



The Los Angeles 100% Renewable Energy Study

# Initial Run Results: Distribution Models


## SB100 Scenario

Bryan Palmintier, Ph.D.

December 5, 2019



# Bulk Power and Distribution Models



# Agenda

## Output Models, Part 2: Distribution System

1. Analysis Overview
2. Methods Introduction
3. Initial Run Results (4.8kV)
4. Discussion/Q&A

# Distribution System Analysis

---

## *Overview*

What are the impacts on the distribution system of:

- Future electricity demand changes?
- Distributed generation?

Approximately how much would required distribution upgrades cost LADWP?

- Includes distributed generation from:
  - Residential and commercial rooftop solar
  - Larger ground-mounted and carport solar
- Analysis conducted only for 2030 & 2045

# Initial Run (Today/March) vs. Final Run (June AG)

## What's **Included** in Initial Run (Today)

2045 analysis

Initial loads (electricity demand)

4.8kV rooftop solar

Two time periods: peak load and high solar with low load

## Initial Run results at **March AG**

Upgrade cost estimates (2030)

34.5kV large-scale local solar (2030)

## What's **Not Included** Today but Will Be in Final Run

2030 & 2045 analysis

Revised loads, including EVs, buses, fast charging

Distribution upgrade cost estimates


34.5kV large-scale local solar

Local storage


Time-series analysis for impacts and curtailments

# Future Distribution Analysis

# Today's Results



# LA100 Distribution Modeling Efforts: Load and Solar






# LA100 Distribution Modeling Efforts: Analysis Types


Rooftop solar adoption  
(dGen)



System-wide expansion plan for  
~1-5 MW local solar at 34.5kV  
(RPM)



Projection of customer adoption on each roof  
*5 samples/feeder*




**Distribution Impact Analysis**

Power flow analysis to look for voltage violations and thermal impacts of customer-adopted solar

Aggregated up and input to capacity expansion model

Random solar deployments



**Hosting Capacity Analysis**

- Snapshot hosting capacity — all feeders
- Dynamic hosting capacity — select feeders


# What is Impact Analysis?

Distribution power-flow study of future operations to check for violations, including:

- **Voltages:**
  - Under: typically from high loads
  - Over: typically from distributed generation (e.g. solar)\*
- **Overloads:**
  - Transformers
  - Lines

Two approaches:

1. **Absolute:** Are upgrades needed?
2. **Relative:** How do things change?




*\*Note: Advanced inverters can help manage both over & under voltages*

# What Is Hosting Capacity? And How Is It Computed?

The amount of solar that can be added to a feeder without causing operational changes

## Key Items:

- Voltage violations
- Overloads
  - Transformers
  - Lines



# What Is Hosting Capacity? And How Is It Computed?


The amount of solar that can be added to a feeder without causing overloads

Key Items:

- Voltage violations
- Overloads

## Key Points:

- Up to a certain point, integrating distribution-connected solar is “free”
- Location matters ... a lot
- Advanced inverters can boost hosting (e.g., 2-3x)
  - Included for all new solar in LA100
- Hosting capacity is not a hard limit ... but we have to pay for upgrades




# Distribution System Analysis

---

*Methodology*


# Step 1: Build Electric Models of LA's Distribution System



# Step 2: Add Loads and Solar

Matched to individual customers:

- Building loads
- Electric vehicle loads
- Distributed solar adoption
- Customer storage (soon)



# Step 3: Lots of Computations



500,000+  
Powerflows

## Pre-Processing

Powerflow  
with PyDSS

Identify  
Items to Fix

## DiTTO

Feeder Model  
Creation

dGen Solar  
Deployments

## Hosting Capacity Setup

Hosting  
Capacity Solar  
Deployments

Config File  
Creation

## Impact Analysis Setup

Config File  
Generation

Model Input  
Creation

Configure  
Model Inputs

Run Powerflow  
with PyDSS

Post Processing Layer 1:  
Impact  
and Hosting Capacity  
Analysis

Post Processing Layer 2:  
Create Summary Dataframes

**DISCO**

Distribution grid Integration Solution CoSt

## Data Analysis

LA100-specific Jupyter Notebooks,  
scripts, etc.

Interactive Data  
Analysis



# Step 3: Lots of Computations—What We Evaluate Today

Based on two time points: “peak demand” and “high solar with low demand”

## 1. Violations because of 2045 load changes:

- Overvoltage
- Undervoltage
- Line overload
- Transformer overload

Compare **2045 load-only** impacts to **today**

## 2. Differences in violations due to 2045 local solar

- Impact analysis: customer deployments ○

Compare 2045 **with** and **without** solar

## 3. Combined load and solar impact analysis:

- Are upgrades needed?
- If not, how difficult are needed upgrades?

May be better or worse with solar

Compare **2045 load + solar** to **today**

# Distribution System Analysis

---

*Initial Run Results (4.8kV)*

*SB100-Moderate Load 2045*

# Reminder: Load and Solar Adoption Levels


- Peak 4.8kV Load = 3.2 GW
  - Bottom-up Building Models (moderate efficiency)
  - Light-duty Electric Vehicles (moderate adoption)
- Total 4.8kV Rooftop Solar = 2.1 GW
  - Based on dGen results (moderate adoption)

# Initial Run: Load Analysis, 2045 Compared to Today

Based on two time points: “peak demand” and “high solar with low demand”

## 1. Violations because of 2045 load changes:


- Overvoltage
- Undervoltage
- Line overload
- Transformer overload



Compare 2045 load-only impacts to today

## 2. Differences in violations due to 2045 local solar


- Impact analysis: customer deployments



Compare 2045 with and without solar

## 3. Combined load and solar impact analysis:

- Are upgrades needed?
- If not, how difficult are needed upgrades?




Compare 2045 Load + Solar to today

Initial Run  
4.8kV


Distribution  
Impacts of  
Load-only

(2045 SB100  
Moderate)

## 2045 Load Increase



## Resulting Violations




*Note: Loads do not include  
demand response shifts*


*Initial Run – For Discussion Purposes Only; Subject to Change*

## Distribution Impacts of 2045 Load-only (continued)

### Violations per Feeder (Load-only)



### Violation Type Breakdown



- 86% of feeders OK with new loads
- Most remaining require only few upgrades

# Initial Run: Solar Analysis, 2045 With and Without Solar

Based on two time points: “peak demand” and “high solar with low demand”

## 1. Violations because of 2045 load changes:

- Overvoltage
- Undervoltage
- Line overload
- Transformer overload

Compare 2045 load-only impacts to today

## 2. Differences in violations due to 2045 local solar

- Impact analysis: customer deployments

Compare 2045 with and without solar

## 3. Combined load and solar impact analysis:

- Are upgrades needed?
- If not, how difficult are needed upgrades?

May be better or worse with solar

Compare 2045 Load + Solar to today


Initial Run  
4.8kV

Distribution  
Impacts of  
Rooftop Solar

(2045 SB100  
Moderate)

*Note: Loads do not include  
demand response shifts*



## Violations Beyond Load





## Distribution Impacts of 2045 Rooftop Solar (continued)

Violation Change with Solar vs. Load-only



Total Violation Count:

- Up: 14% of Feeders
- Down: 18%
- The same: 69%

# Initial Run: Load and Solar Analysis, 2045—Will It Fit?

Based on two time points: “peak demand” and “high solar with low demand”

## 1. Violations because of 2045 load changes:

- Overvoltage
- Undervoltage
- Line overload
- Transformer overload

Compare 2045 load-only impacts to today

## 2. Differences in violations due to 2045 local solar

- Impact analysis: customer deployments

Compare 2045 with and without solar

## 3. Combined load and solar impact analysis:


- Are upgrades needed?
- If not, how difficult are needed upgrades?

Compare 2045 Load + Solar to today

# Are Upgrades Needed?

Initial Run 4.8kV

Are upgrades needed to accommodate estimated load + rooftop solar? If not, how hard will it be to upgrade?




- No upgrades needed
- Fix overvoltage, typically from solar (\$-\$\$)
- Fix undervoltage, typically from load (\$-\$\$)
- Line upgrade (\$\$\$+)
- Service transformer upgrade (\$-\$\$)

Note: Loads do not include demand response shifts

## Are Upgrades Needed with Loads and Rooftop Solar?

4.8kV Feeder Upgrades Needed with Solar+Load (SB100-Moderate, 2045)



- No upgrades needed in 78% of feeders with new loads and solar
- Only 2.3% of feeders would require line upgrades (\$\$\$)

# Initial Run Summary for SB100 Moderate

- Expected load changes are OK for most (86%) 4.8kV feeders
  - Most common concern = undervoltage
- Adding rooftop solar can both:
  - Increase violations (14% of feeders) and
  - Decrease violations (18% of feeders)
- **Most 4.8kV feeders (78%) are OK with both solar and rooftop PV**
- But these results will change for Final Run

# Coming Up

## March

- Distribution analysis and upgrade cost estimates for 2030, including:
  - Analysis of large-scale local solar on 34.5kV lines

## June

- Distribution analysis and upgrade costs for 2030 and 2045 based on:
  - Revised loads, including EVs, buses, and fast charging
  - Local storage
  - Full time-series analysis for impacts and curtailments

# Questions?

---



The Los Angeles 100% Renewable Energy Study