

LORP Synopsis for April 2025

Compliance Comments

Flows were above the minimum flow for the month.

Maintenance

Activities for the month on the Lower Owens River included the following:

- Current metering continues the development of discharge curves at all in-river flow monitoring sites and are used to develop velocity indexing tables.
- Some in-river station measurements have fluctuated as a result of shifting sedimentation in the river, requiring additional indexing to increase the accuracy of measurements.

Operations

Below are flow changes that occurred during the month:

- LORPS Langemann from 10 cfs to 13 cfs on April 1, 2025.
- LORP Intake from 42.2 to 58 cfs on April 8, 2025.

Waterfowl Area Monthly Report

Synopsis (for Runoff Year 2025-2026)

Implementation of the Interim Management and Monitoring Plan continued, which includes the seasonal flooding regime and a fixed waterfowl acreage goal of 500 acres.

On March 1, 2025 (RY 2024-25) flows to all units were set to 0 cfs.

Flow Rates and Wetted Acreage Summary (for Runoff Year 2024-25)

	Inflow (cfs)	Date Set	Wetted Acreage	Date of Survey
Drew Unit	off	4/16/2021		
Waggoner Unit	off	3/1/2024		
	7.5	9/15/2024	145	11/3/2024
	3.0	11/1/2024	185	3/1/2025
	off	3/1/2025		
Winterton Unit	off	3/1/2024		
	2.5	9/15/2024	138	11/6/2024
	3.0	11/1/2024	237	3/1/2025
	off	3/1/2025		
Thibaut Unit	off	3/1/2024		
	7.5	9/15/2024	226	11/3/2024
	2.5	11/1/2024	249	3/1/2025
	off	3/1/2025		

APRIL 2025 IN-RIVER STATION CURRENT METERING SUMMARY

Station	Date	Metered Flow	Station Begin Flow	Station End Flow	Shift Applied	Notes	
LORP Intake	4/15/2025	58.08	58.20	57.80	0	gage height	3.74
At Mazourka Canyon Road	4/15/2025	55.70	59.50	60.60	-4	gage height	3.47
At Reinhackle Springs	4/15/2025	57.98	66.50	65.50	-8	gage height	4.10

Month: April
Year: 2025

Date	Intake			Blackrock Ditch Return		Billy Lake Return		Mazourka Canyon Road			Locust Ditch Return		Georges Ditch Return		Reinhackle Springs			Alabama Gates Release		Above Pumpstation			Pumpback Discharge		Lange-mann Release to Delta	Weir to Delta	River Daily Avg
	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Flow	Avg Month to Date		
04/01/25	42	42	15	1	1	2	1	49	49	15	0	0	0	0	51	51	15	0	0	48	48	15	36	36	12	0	48
04/02/25	44	43	15	1	1	1	1	46	49	15	0	0	0	0	43	51	15	0	0	47	48	15	34	35	13	0	45
04/03/25	42	43	15	1	1	1	1	47	49	15	0	0	1	0	45	50	15	0	0	48	48	15	35	35	13	0	46
04/04/25	42	42	15	1	1	1	1	61	50	15	0	0	1	0	46	50	15	0	0	48	48	15	35	35	13	0	49
04/05/25	42	42	15	1	1	1	1	52	50	15	0	0	0	0	55	50	15	0	0	47	48	15	34	35	13	0	49
04/06/25	42	42	15	1	1	1	1	50	50	15	0	0	0	0	52	50	15	0	0	47	48	15	34	35	13	0	48
04/07/25	42	42	15	1	1	2	1	50	50	15	0	0	0	0	50	50	15	0	0	47	48	15	34	35	13	0	47
04/08/25	52	43	15	1	1	2	1	49	50	15	0	0	1	0	49	50	15	0	0	48	48	15	35	35	13	0	50
04/09/25	57	44	15	1	1	2	1	52	50	15	0	0	0	0	49	50	15	0	0	51	48	15	38	35	13	0	52
04/10/25	57	45	15	1	1	2	1	60	51	15	0	0	0	0	50	50	15	0	0	51	48	15	38	35	13	0	55
04/11/25	58	46	15	1	1	2	1	62	52	15	0	0	0	0	57	50	15	0	0	50	48	15	37	35	13	0	57
04/12/25	58	47	15	1	1	2	1	63	53	15	0	0	0	0	57	50	15	0	0	49	49	15	36	36	13	0	57
04/13/25	57	48	15	1	1	2	2	64	54	15	0	0	0	0	59	51	15	0	0	49	48	15	36	36	13	0	57
04/14/25	57	49	15	1	1	2	2	62	54	15	0	0	0	0	62	52	15	0	0	49	48	15	36	36	13	0	58
04/15/25	57	50	15	1	1	1	1	55	55	15	0	0	0	0	55	52	15	0	0	52	49	15	39	36	13	0	55
04/16/25	57	51	15	1	1	1	1	55	55	15	0	0	0	0	54	52	15	0	0	54	49	15	41	36	13	0	55
04/17/25	58	52	15	1	1	1	1	55	56	15	0	0	0	0	54	53	15	0	0	56	50	15	43	37	13	0	56
04/18/25	58	53	15	1	1	1	1	56	56	15	0	0	0	0	55	54	15	0	0	57	50	15	44	37	13	0	57
04/19/25	57	54	15	1	1	1	1	56	56	15	0	0	0	0	56	54	15	0	0	56	51	15	43	37	13	0	56
04/20/25	57	55	15	1	1	1	1	56	56	15	0	0	0	0	57	54	15	0	0	56	51	15	43	38	13	0	57
04/21/25	57	56	15	1	1	1	1	55	57	15	0	0	0	0	56	55	15	0	0	55	52	15	42	38	13	0	56
04/22/25	57	57	15	1	1	1	1	54	57	15	0	0	0	0	56	55	15	0	0	56	53	15	43	38	13	0	56
04/23/25	57	57	15	2	1	1	1	54	57	15	0	0	0	0	56	56	15	0	0	57	53	15	44	38	13	0	56
04/24/25	58	57	15	1	1	1	1	54	57	15	0	0	0	0	55	56	15	0	0	57	54	15	44	39	13	0	56
04/25/25	57	57	15	1	1	1	1	54	57	15	0	0	0	0	55	56	15	0	0	57	54	15	44	39	13	0	56
04/26/25	57	57	15	1	1	1	1	54	56	15	0	0	0	0	57	56	15	0	0	57	54	15	44	39	13	0	56
04/27/25	57	57	15	1	1	2	1	54	56	15	0	0	0	0	56	56	15	0	0	57	55	15	44	39	13	0	56
04/28/25	57	57	15	1	1	2	1	54	55	15	0	0	0	0	57	56	15	0	0	57	56	15	44	39	13	0	56
04/29/25	57	57	15	1	1	2	1	54	55	15	0	0	0	0	58	56	15	0	0	57	56	15	44	39	13	0	57
04/30/25	57	57	15	1	1	1	1	54	55	15	0	0	0	0	57	56	15	0	0	57	56	15	44	40	13	0	56
Monthly Avg	54							55							54					53							54

Lower Owens River Project Flow Report for 04/01/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			42	42	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.6	1			
Mazourka Canyon Road			49	49	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			51	51	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			48	48	15
Pump Station			36	38	
Langemann Gate to Delta			12	10	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			48	48	

Pump Station Month-to-Date Average Flow 36 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.59 ft	(Last Collected: 03/26/2025)
Lower Twin Lake Gage Read	2.50 ft	
Goose Lake Gage Read	2.40 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/02/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			44	43	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	1			
Mazourka Canyon Road			46	49	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			43	51	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			47	48	15
Pump Station			34	37	
Langemann Gate to Delta			13	10	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			45	48	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.59 ft	(Last Collected: 03/26/2025)
Lower Twin Lake Gage Read	2.50 ft	
Goose Lake Gage Read	2.40 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/03/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			42	43	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	1			
Mazourka Canyon Road			47	49	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	1	0			
Reinhackle Springs			45	50	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			48	48	15
Pump Station			35	37	
Langemann Gate to Delta			13	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			46	47	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.59 ft	(Last Collected: 03/26/2025)
Lower Twin Lake Gage Read	2.50 ft	
Goose Lake Gage Read	2.40 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/04/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			42	42	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.4	1			
Mazourka Canyon Road			61	50	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			46	50	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			48	48	15
Pump Station			35	37	
Langemann Gate to Delta			13	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			49	47	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.59 ft	(Last Collected: 03/26/2025)
Lower Twin Lake Gage Read	2.50 ft	
Goose Lake Gage Read	2.40 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/05/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			42	42	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			52	50	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			55	50	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			47	48	15
Pump Station			34	37	
Langemann Gate to Delta			13	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			49	48	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.59 ft	(Last Collected: 03/26/2025)
Lower Twin Lake Gage Read	2.50 ft	
Goose Lake Gage Read	2.40 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/06/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			42	42	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	1			
Mazourka Canyon Road			50	50	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			52	50	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			47	48	15
Pump Station			34	37	
Langemann Gate to Delta			13	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			48	48	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.59 ft	(Last Collected: 03/26/2025)
Lower Twin Lake Gage Read	2.50 ft	
Goose Lake Gage Read	2.40 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/07/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			42	42	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.6	1			
Mazourka Canyon Road			50	50	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			50	50	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			47	48	15
Pump Station			34	36	
Langemann Gate to Delta			13	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			47	48	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.59 ft	(Last Collected: 03/26/2025)
Lower Twin Lake Gage Read	2.50 ft	
Goose Lake Gage Read	2.40 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/08/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			52	43	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.6	1			
Mazourka Canyon Road			49	50	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	1	0			
Reinhackle Springs			49	50	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			48	48	15
Pump Station			35	36	
Langemann Gate to Delta			13	12	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			50	48	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.59 ft	(Last Collected: 03/26/2025)
Lower Twin Lake Gage Read	2.50 ft	
Goose Lake Gage Read	2.40 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/09/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			57	44	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.6	1			
Mazourka Canyon Road			52	50	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			49	50	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			51	48	15
Pump Station			38	36	
Langemann Gate to Delta			13	12	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			52	48	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 04/09/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/10/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			57	45	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.6	1			
Mazourka Canyon Road			60	51	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			50	50	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			51	48	15
Pump Station			38	36	
Langemann Gate to Delta			13	12	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			54	49	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 04/09/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/11/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			58	46	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.6	2			
Mazourka Canyon Road			62	52	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			57	50	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			50	48	15
Pump Station			37	36	
Langemann Gate to Delta			13	12	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			57	49	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 04/09/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/12/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			58	47	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.6	2			
Mazourka Canyon Road			63	53	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			57	50	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			49	49	15
Pump Station			36	36	
Langemann Gate to Delta			13	12	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			57	50	

Pump Station Month-to-Date Average Flow 36 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 04/09/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/13/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			57	48	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.6	2			
Mazourka Canyon Road			64	54	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			59	51	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			49	48	15
Pump Station			36	36	
Langemann Gate to Delta			13	13	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			57	50	

Pump Station Month-to-Date Average Flow 36 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 04/09/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/14/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			57	49	15
Blackrock Ditch Return (augmentation)	2	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.6	2			
Mazourka Canyon Road			62	54	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			62	52	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			49	48	15
Pump Station			36	36	
Langemann Gate to Delta			13	13	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			58	51	

Pump Station Month-to-Date Average Flow 36 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 04/09/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/15/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			57	50	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	2			
Mazourka Canyon Road			55	55	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			55	52	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			52	49	15
Pump Station			39	36	
Langemann Gate to Delta			13	13	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			55	51	

Pump Station Month-to-Date Average Flow 36 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 04/09/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/16/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			57	51	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.4	2			
Mazourka Canyon Road			55	55	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			54	52	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			54	49	15
Pump Station			41	36	
Langemann Gate to Delta			13	13	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			55	52	

Pump Station Month-to-Date Average Flow 36 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 04/09/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/17/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			58	52	15
Blackrock Ditch Return (augmentation)	2	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	2			
Mazourka Canyon Road			55	56	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			54	53	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			56	50	15
Pump Station			43	37	
Langemann Gate to Delta			13	13	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	53	

Pump Station Month-to-Date Average Flow 37 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 04/09/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/18/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			58	53	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			56	56	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			55	54	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			57	50	15
Pump Station			44	37	
Langemann Gate to Delta			13	13	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	53	

Pump Station Month-to-Date Average Flow 37 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 04/09/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/19/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			57	54	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			56	56	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			56	54	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			56	51	15
Pump Station			43	38	
Langemann Gate to Delta			13	13	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	54	

Pump Station Month-to-Date Average Flow 37 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 04/09/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/20/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			57	55	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	2			
Mazourka Canyon Road			56	56	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			57	54	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			56	51	15
Pump Station			43	38	
Langemann Gate to Delta			13	13	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	54	

Pump Station Month-to-Date Average Flow 38 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 04/09/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/21/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			57	56	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	2			
Mazourka Canyon Road			55	57	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			56	55	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			55	52	15
Pump Station			42	39	
Langemann Gate to Delta			13	13	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	55	

Pump Station Month-to-Date Average Flow 38 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 04/09/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/22/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			57	57	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	1			
Mazourka Canyon Road			54	57	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			56	55	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			56	53	15
Pump Station			43	40	
Langemann Gate to Delta			13	13	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	55	

Pump Station Month-to-Date Average Flow 38 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 04/09/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.53 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/23/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			57	57	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	1			
Mazourka Canyon Road			54	57	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			56	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			57	53	15
Pump Station			44	40	
Langemann Gate to Delta			13	13	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	56	

Pump Station Month-to-Date Average Flow 38 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.66 ft	(Last Collected: 04/23/2025)
Lower Twin Lake Gage Read	2.17 ft	
Goose Lake Gage Read	2.70 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/24/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			58	57	15
Blackrock Ditch Return (augmentation)	2	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	1			
Mazourka Canyon Road			54	57	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			55	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			57	54	15
Pump Station			44	41	
Langemann Gate to Delta			13	13	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	56	

Pump Station Month-to-Date Average Flow 38 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.66 ft	(Last Collected: 04/23/2025)
Lower Twin Lake Gage Read	2.17 ft	
Goose Lake Gage Read	2.70 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/25/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			57	57	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			54	57	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			55	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			57	54	15
Pump Station			44	41	
Langemann Gate to Delta			13	13	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	56	

Pump Station Month-to-Date Average Flow 39 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.66 ft	(Last Collected: 04/23/2025)
Lower Twin Lake Gage Read	2.17 ft	
Goose Lake Gage Read	2.70 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/26/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			57	57	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			54	56	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			57	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			57	54	15
Pump Station			44	41	
Langemann Gate to Delta			13	13	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	56	

Pump Station Month-to-Date Average Flow 39 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.66 ft	(Last Collected: 04/23/2025)
Lower Twin Lake Gage Read	2.17 ft	
Goose Lake Gage Read	2.70 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/27/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			57	57	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.6	1			
Mazourka Canyon Road			54	56	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			56	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			57	55	15
Pump Station			44	42	
Langemann Gate to Delta			13	13	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	56	

Pump Station Month-to-Date Average Flow 39 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.66 ft	(Last Collected: 04/23/2025)
Lower Twin Lake Gage Read	2.17 ft	
Goose Lake Gage Read	2.70 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/28/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			57	57	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.7	1			
Mazourka Canyon Road			54	55	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			57	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			57	56	15
Pump Station			44	43	
Langemann Gate to Delta			13	13	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	56	

Pump Station Month-to-Date Average Flow 39 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.66 ft	(Last Collected: 04/23/2025)
Lower Twin Lake Gage Read	2.17 ft	
Goose Lake Gage Read	2.70 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/29/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			57	57	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.6	1			
Mazourka Canyon Road			54	55	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			58	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			57	56	15
Pump Station			44	43	
Langemann Gate to Delta			13	13	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	56	

Pump Station Month-to-Date Average Flow 39 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.66 ft	(Last Collected: 04/23/2025)
Lower Twin Lake Gage Read	2.17 ft	
Goose Lake Gage Read	2.70 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 04/30/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			57	57	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	1			
Mazourka Canyon Road			54	55	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			57	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			57	56	15
Pump Station			44	43	
Langemann Gate to Delta			13	13	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	56	

Pump Station Month-to-Date Average Flow 40 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	0 cfs	03/01/2025
Winterton	237 Acres	03/01/2025	0 cfs	03/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	0 cfs	03/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.66 ft	(Last Collected: 04/23/2025)
Lower Twin Lake Gage Read	2.17 ft	
Goose Lake Gage Read	2.70 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Ian Keller/Jason Olin

DATE: March 31, 2025

REQUESTED BY: Tony Tillemans x32259

FLOW CHANGE LOCATION **Langemann Gate at Pumpstation**

START DATE: Tuesday, April 1, 2025 TIME: morning

CHANGE FLOW: FROM: 10 cfs TO: 13 cfs at LORPS Langemann

C: Adam Perez
Eric Tillemans
Chad Lamacchia
Ben Arcularius

Ben Butler
Jason Olin
Gary Reiser
Bruce Peterson

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Joseph McGuire/Courtnie Cappello

DATE: April 7, 2025

REQUESTED BY: Tony Tillemans x32259

FLOW CHANGE LOCATION **LORP Intake**

START DATE: Tuesday, April 8, 2025 TIME: morning

CHANGE FLOW: From: 42.2 cfs To: 58 cfs

To maintain required flows to the LORP, monitor and make adjustments to the Aqueduct Intake gates for at least one day following this flow change.

C:	Adam Perez	Ben Butler
	Eric Tillemans	Jason Olin
	Forest Mathieu	Bruce Peterson
	Ryan Yeager	Gary Reiser
	Joe Bowling	Chad Lamacchia

Quality Assurance and Calibration Procedures

The Los Angeles Department of Water and Power has a set standard to assure quality of all hydrological data collected. Procedures used to QA data vary based on the type of data collected and the device used to measure flow.

Data collected from sites utilizing area velocity flow meters are electronically monitored continuously. Sites are physically visited most days of the week to assure debris or vandalism hasn't affected the reading. Errors in the data collected may arise from several sources:

1. The transducers which detect the stage height and velocities have a tendency to drift.
2. Power outages occur occasionally thereby preventing the recording of data to the data loggers.
3. Occasionally the data loggers themselves malfunction.
4. Data can be lost or corrupted when it is transferred from the data loggers to the laptop.

Errors in discharge can originate from the instability of the relationship between velocity and stage height. This relationship varies temporally. It is affected by changes in the streambed that results from the flow of water over the bed, such as scour and fill, aquatic growth, ice, debris, or bed roughness.

To compensate for changes in the constantly shifting conditions multiple current meter measurements at each location per USGS standards are conducted per month. The current meter shots are taken at 2 foot intervals horizontally across the lined sections or 1 foot intervals at the sites where the measurements are taken in culverts. In each vertical section two separate measurements are taken (0.2 and 0.8) of the depth to achieve the best velocity average in the vertical. These vertical discharges are then added together to obtain a total flow in the section. The current meter data is logged in an on-board computer tracking the measurements as taken. That data is then extracted from the on-board computer to a PC using the FlowPack software that allows analysis of the data for erroneous measurements and is then converted to an Excel spreadsheet for ease of storage and printing. See Examples 1 – 3 for printout of software used to validate the current meter data.

Current meter data is used to develop velocity index tables. The tables require a minimum of 6 meter shots. After a table has been developed it is then downloaded into the on-site SonTek software which takes into account any variables within the meter section and applies any shifts to the discharge.

Data is collected and logged every 10 minutes utilizing SonTek area velocity flow meters. The data is downloaded from the meters once per month utilizing software provided by SonTek. The software "ViewArgonaut" gives us the ability to check items relevant to the performance of the meter. Battery voltage, beam strength, noise ratios, depth, and cell distance. (See Example 4) The software provides a trend of the data collected and displays it for quick comparisons, flagging discrepancies, one day at a time. Utilizing the ViewArgonaut software monthly reports are generated and the data is

reviewed. Using the current meter data collected during the month shifts are applied to the discharge to assure accuracy.

Augmentation Flows

Flows at several of the augmentation points are measured using weirs and flumes at sites that were pre-existing. Billy Lake has a one foot Parshall flume, Locust and Georges Returns have three foot weirs installed. All have stilling wells with dataloggers installed. The water surface elevation in the stillwell is measured each time the site is visited and verified it matches the staff gage for correct water depth through the measuring device. The still wells are flushed once every two months to assure the communication line is open and free of debris. The gage height data is logged on a module every 15 minutes. The modules are changed and processed every two weeks. Software used to process the data gives an hourly average gage and converts it to flow. It also gives the maximum and minimum flows for each day and time stamps it. The data is reviewed for any discrepancies which can be caused as a result of debris plugging the measuring device, a plugged stillwell, low batteries, etc.

SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:

[Open a FlowTracker file](#)[Open many FlowTracker files/folders](#)

The current export settings are:

- ☒ Show Discharge Summary Report
- ☒ Export ASCII Discharge file (DIS)
- ☒ Export ASCII Control file (CTL)
- ☒ Export ASCII Summary file (SUM)
- ☒ Export ASCII Data file (DAT)
- ☒ Export FlowPack file (FPX)
- ☒ Put Headers on ASCII files

[Connect to a FlowTracker](#)

To download data and run diagnostics

[Program Settings](#)[Quality Control Settings](#)[Show User's Manual](#)[Show Technical Manual](#)[Show Quick Start](#)[About FlowTracker](#)

English



A YSI Environmental Company

070706.ORABR.LOR.WAD

Discharge Measurement Summary

Date Generated: Thu Sep 27 2007

File Information

File Name 070706.ORABR.LOR.WAD
Start Date and Time 2007/07/06 07:48:17

Site Details

Site Name ORABR
Operator(s) DJT

System Information

Sensor Type FlowTracker
Serial # P1685
CPU Firmware Version 3.2
Software Ver 2.11

Units

(English Units)

Distance ft
Velocity ft/s
Area ft²
Discharge cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.1%	0.5%
Velocity	0.3%	1.4%
Width	0.1%	0.1%
Method	0.8%	-
# Stations	1.6%	-
Overall	2.1%	1.8%

Summary

Averaging Int.	40	# Stations	32
Start Edge	REW	Total Width	48.100
Mean SNR	18.7 dB	Total Area	69.016
Mean Temp	73.68 °F	Mean Depth	1.435
Disch. Equation	Mid-Section	Mean Velocity	0.6419
		Total Discharge	44.3025

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	07:48	23.60	None	0.000	0.0	0.0	0.0000	1.00	0.0000	0.000	0.0000	0.0
1	07:48	24.60	0.6	0.360	0.6	0.144	0.2762	1.00	0.2762	0.360	0.0994	0.2
2	07:50	25.60	0.6	0.640	0.6	0.256	0.5102	1.00	0.5102	0.640	0.3266	0.7
3	07:51	26.60	0.6	0.880	0.6	0.352	0.5938	1.00	0.5938	0.880	0.5225	1.2
4	07:52	27.60	0.6	1.180	0.6	0.472	0.6257	1.00	0.6257	1.180	0.7383	1.7
5	07:54	28.60	0.6	1.390	0.6	0.556	0.6302	1.00	0.6302	1.390	0.8761	2.0
6	07:55	29.60	0.2/0.8	1.520	0.2	1.216	0.8130	1.00	0.7078	1.520	1.0759	2.4
6	07:56	29.60	0.2/0.8	1.520	0.8	0.304	0.6027					
7	07:58	30.60	0.8/0.2	1.690	0.2	1.352	0.8468	1.00	0.7664	1.690	1.2952	2.9
7	07:57	30.60	0.8/0.2	1.690	0.8	0.338	0.6860					
8	07:59	31.60	0.2/0.8	1.700	0.2	1.360	0.8146	1.00	0.7037	2.040	1.4357	3.2
8	08:00	31.60	0.2/0.8	1.700	0.8	0.340	0.5928					
9	08:03	33.00	0.8/0.2	1.680	0.2	1.344	0.8383	1.00	0.7408	2.016	1.4935	3.4
9	08:01	33.00	0.8/0.2	1.680	0.8	0.336	0.6434					
10	08:05	34.00	0.2/0.8	1.600	0.2	1.280	0.8724	1.00	0.7398	2.400	1.7757	4.0
10	08:06	34.00	0.2/0.8	1.600	0.8	0.320	0.6073					
11	08:08	36.00	0.8/0.2	1.520	0.2	1.216	0.8186	1.00	0.6995	3.040	2.1264	4.8
11	08:07	36.00	0.8/0.2	1.520	0.8	0.304	0.5804					
12	08:09	38.00	0.2/0.8	1.500	0.2	1.200	0.8957	1.00	0.7461	3.000	2.2382	5.1
12	08:11	38.00	0.2/0.8	1.500	0.8	0.300	0.5965					
13	08:12	40.00	0.2/0.8	1.490	0.2	1.192	0.8245	1.00	0.6321	2.980	1.8837	4.3
13	08:13	40.00	0.2/0.8	1.490	0.8	0.298	0.4396					
14	08:15	42.00	0.2/0.8	1.510	0.2	1.208	0.8514	1.00	0.7548	3.020	2.2791	5.1
14	08:16	42.00	0.2/0.8	1.510	0.8	0.302	0.6581					
15	08:18	44.00	0.8/0.2	1.600	0.2	1.280	0.8278	1.00	0.7026	3.200	2.2484	5.1
15	08:17	44.00	0.8/0.2	1.600	0.8	0.320	0.5774					
16	08:19	46.00	0.2/0.8	1.620	0.2	1.296	0.8018	1.00	0.6916	3.240	2.2409	5.1
16	08:20	46.00	0.2/0.8	1.620	0.8	0.324	0.5814					
17	08:22	48.00	0.8/0.2	1.700	0.2	1.360	0.8396	1.00	0.7756	3.400	2.6372	6.0
17	08:21	48.00	0.8/0.2	1.700	0.8	0.340	0.7116					
18	08:23	50.00	0.2/0.8	1.800	0.2	1.440	0.9016	1.00	0.8251	3.600	2.9703	6.7
18	08:24	50.00	0.2/0.8	1.800	0.8	0.360	0.7487					
19	08:26	52.00	0.8/0.2	1.680	0.2	1.344	0.8271	1.00	0.7269	3.360	2.4425	5.5
19	08:25	52.00	0.8/0.2	1.680	0.8	0.336	0.6266					
20	08:27	54.00	0.2/0.8	1.780	0.2	1.424	0.7795	1.00	0.6763	3.560	2.4076	5.4
20	08:28	54.00	0.2/0.8	1.780	0.8	0.356	0.5732					
21	08:30	56.00	0.8/0.2	1.820	0.2	1.456	0.7329	1.00	0.6097	3.640	2.2193	5.0
21	08:29	56.00	0.8/0.2	1.820	0.8	0.364	0.4865					
22	08:32	58.00	0.2/0.8	1.820	0.2	1.456	0.7123	1.00	0.5540	3.640	2.0163	4.6
22	08:34	58.00	0.2/0.8	1.820	0.8	0.364	0.3957					
23	08:36	60.00	0.8/0.2	1.800	0.2	1.440	0.6949	1.00	0.6017	3.600	2.1660	4.9
23	08:35	60.00	0.8/0.2	1.800	0.8	0.360	0.5085					

SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:

[Open a FlowTracker file](#)[Open many FlowTracker files/folders](#)**The current export settings are:**

- ☒ Show Discharge Summary Report
- ☒ Export ASCII Discharge file (DIS)
- ☒ Export ASCII Control file (CTL)
- ☒ Export ASCII Summary file (SUM)
- ☒ Export ASCII Data file (DAT)
- ☒ Export FlowPack file (FPX)
- ☒ Put Headers on ASCII files

[Connect to a FlowTracker](#)

To download data and run diagnostics




[Program Settings](#)[Quality Control Settings](#)[Show User's Manual](#)[Show Technical Manual](#)[Show Quick Start](#)[About FlowTracker](#)

English



A YSI Environmental Company

070706.0RABR.LOR.WAD




Quality Control

St	Loc	%Dep	Message
13	40.00	0.8	High standard error: 0.024

Automatic Quality Control Test (BeamCheck)

Fri Jul 6 07:47:10 PDT 2007



SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:

[Open a FlowTracker file](#)[Open many FlowTracker files/folders](#)**The current export settings are:**

- ☒ Show Discharge Summary Report
- ☒ Export ASCII Discharge file (DIS)
- ☒ Export ASCII Control file (CTL)
- ☒ Export ASCII Summary file (SUM)
- ☒ Export ASCII Data file (DAT)
- ☒ Export FlowPack file (FPX)
- ☒ Put Headers on ASCII files

[Connect to a FlowTracker](#)

To download data and run diagnostics




[Program Settings](#)[Quality Control Settings](#)[Show User's Manual](#)[Show Technical Manual](#)[Show Quick Start](#)[About FlowTracker](#)

English



A YSI Environmental Company


070706.0RABR.LOR.WAD





Quality Control

St	Loc	%Dep	Message
13	40.00	0.8	High standard error: 0.024

Automatic Quality Control Test (BeamCheck)



FileName: BROR_070801_a.arg (Argonaut- SW 3000 kHz)



System	Argonaut-SW
Frequency	3000 kHz
File	BROR_070801_a
File Size	65.18 kB
Sample No	1
Sample Date	02/07/2007
Sample Time	13:28:38
Time Interval	180

Velocity Data:	
V1/X/E(cm/s)	27.8
V2/Y/N(cm/s)	2.4
V3/Z/U(cm/s)	--
Speed (cm/s)	27.9
Direction(deg)	85.1

Discharge Summary:	
V Beam (m)	0.426
Stage (m)	1.304
VMean (cm/s)	22.7
Flow (cfs)	50.21
Area (m2)	6.26
Vol (acre-ft)	0.7

Diagnostic Data:	
SNR1 (dB)	61
SNR2 (dB)	61
SNR3 (dB)	--
StErr1 (cm/s)	0.9
StErr2 (cm/s)	0.8
StErr3 (cm/s)	--
Mean StDev	0.9
Battery (V)	12.4

Party: BLP / BJA	Width: 29.2 ft	Processed by: BJA
Boat/Motor: BOAT	Area: 149 ft²	Mean Velocity: 0.402 ft/s
Gage Height: 4.67 ft	G.H.Change: 0.000 ft	Discharge: 58.1 ft³/s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.00°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft²	Diff.: 0.000%
Depth: Composite (BT)	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:		ADCP:	
BT 3-Beam Solution: YES	Max. Vel.: 1.32 ft/s	Type/Freq.: StreamPro / 2000 kHz	
WT 3-Beam Solution: YES	Max. Depth: 5.81 ft	Serial #: 2370	Firmware: 31.17
BT Error Vel.: 0.33 ft/s	Mean Depth: 5.07 ft	Bin Size: 17 cm	Blank: 3 cm
WT Error Vel.: 0.98 ft/s	% Meas.: 65.95	BT Mode: 10	BT Pings: 2
BT Up Vel.: 1.00 ft/s	Water Temp.: None	WT Mode: 12	WT Pings: 6
WT Up Vel.: 1.64 ft/s	ADCP Temp.: 68.6 °F		
Use Weighted Mean Depth: YES			

Performed Diag. Test: YES
 Performed Moving Bed Test: NO
 Performed Compass Calibration: NO Evaluation: NO
 Meas. Location: BRIDGE

Project Name: 0088_0.mmt
 Software: 2.26.00.04

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
002	L	2	2	39	7.95	39.8	8.19	2.47	0.494	58.9	26	132	12:31	12:32	0.52	0.45	0	0
003	R	2	2	40	8.16	40.4	8.58	2.19	1.20	60.5	29	151	12:32	12:33	0.68	0.40	13	0
005	R	2	2	32	8.26	40.6	9.04	2.26	0.953	61.1	36	187	12:34	12:34	0.88	0.33	38	0
006	L	2	2	34	8.02	36.6	9.50	2.30	2.08	58.5	24	117	12:34	12:35	0.69	0.50	35	0
007	R	2	2	44	6.89	34.1	7.06	2.58	0.706	51.4	31	157	12:36	12:37	0.54	0.33	25	0
Mean		2	2	37	7.85	38.3	8.48	2.36	1.09	58.1	29	149	Total	00:06	0.66	0.40	22	0
SDev		0	0	5	0.555	2.85	0.929	0.161	0.616	3.90	4.5	26.5			0.14	0.08		
SD/M		0.0%	0.0%	13.2%	7.1%	7.4%	11.0%	6.8%	56.7%	6.7%	15.5%	17.9%			21.6%	18.8%		

Remarks:

Discharge for transects in *italics* have a total Q more than 5% from the mean

Blackrock Return Ditch

Station 0208

Date	Flow (cfs)
4/1/2025	1.08
4/2/2025	1.33
4/3/2025	1.23
4/4/2025	0.99
4/5/2025	0.96
4/6/2025	1.11
4/7/2025	1.11
4/8/2025	1.17
4/9/2025	1.21
4/10/2025	1.26
4/11/2025	1.24
4/12/2025	1.17
4/13/2025	1.30
4/14/2025	1.40
4/15/2025	1.13
4/16/2025	1.22
4/17/2025	1.39
4/18/2025	1.01
4/19/2025	0.98
4/20/2025	1.05
4/21/2025	1.22
4/22/2025	1.24
4/23/2025	1.51
4/24/2025	1.48
4/25/2025	1.28
4/26/2025	1.22
4/27/2025	1.24
4/28/2025	1.15
4/29/2025	1.10
4/30/2025	1.16

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/1/2025	12:00:00 AM	0.4
4/1/2025	12:15:00 AM	0.4
4/1/2025	12:30:00 AM	0.4
4/1/2025	12:45:00 AM	0.4
4/1/2025	1:00:00 AM	0.4
4/1/2025	1:15:00 AM	0.41
4/1/2025	1:30:00 AM	0.41
4/1/2025	1:45:00 AM	0.41
4/1/2025	2:00:00 AM	0.41
4/1/2025	2:15:00 AM	0.41
4/1/2025	2:30:00 AM	0.41
4/1/2025	2:45:00 AM	0.41
4/1/2025	3:00:00 AM	0.41
4/1/2025	3:15:00 AM	0.41
4/1/2025	3:30:00 AM	0.42
4/1/2025	3:45:00 AM	0.42
4/1/2025	4:00:00 AM	0.42
4/1/2025	4:15:00 AM	0.42
4/1/2025	4:30:00 AM	0.42
4/1/2025	4:45:00 AM	0.42
4/1/2025	5:00:00 AM	0.42
4/1/2025	5:15:00 AM	0.42
4/1/2025	5:30:00 AM	0.42
4/1/2025	5:45:00 AM	0.43
4/1/2025	6:00:00 AM	0.43
4/1/2025	6:15:00 AM	0.43
4/1/2025	6:30:00 AM	0.43
4/1/2025	6:45:00 AM	0.43
4/1/2025	7:00:00 AM	0.43
4/1/2025	7:15:00 AM	0.43
4/1/2025	7:30:00 AM	0.43
4/1/2025	7:45:00 AM	0.44
4/1/2025	8:00:00 AM	0.44
4/1/2025	8:15:00 AM	0.44
4/1/2025	8:30:00 AM	0.44
4/1/2025	8:45:00 AM	0.44
4/1/2025	9:00:00 AM	0.44
4/1/2025	9:15:00 AM	0.44
4/1/2025	9:30:00 AM	0.44
4/1/2025	9:45:00 AM	0.44
4/1/2025	10:00:00 AM	0.45
4/1/2025	10:15:00 AM	0.45
4/1/2025	10:30:00 AM	0.45
4/1/2025	10:45:00 AM	0.45
4/1/2025	11:00:00 AM	0.45
4/1/2025	11:15:00 AM	0.45

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/1/2025	11:30:00 AM	0.45
4/1/2025	11:45:00 AM	0.45
4/1/2025	12:00:00 PM	0.46
4/1/2025	12:15:00 PM	0.46
4/1/2025	12:30:00 PM	0.46
4/1/2025	12:45:00 PM	0.46
4/1/2025	1:00:00 PM	0.46
4/1/2025	1:15:00 PM	0.46
4/1/2025	1:30:00 PM	0.46
4/1/2025	1:45:00 PM	0.46
4/1/2025	2:00:00 PM	0.47
4/1/2025	2:15:00 PM	0.47
4/1/2025	2:30:00 PM	0.47
4/1/2025	2:45:00 PM	0.47
4/1/2025	3:00:00 PM	0.48
4/1/2025	3:15:00 PM	0.48
4/1/2025	3:30:00 PM	0.48
4/1/2025	3:45:00 PM	0.49
4/1/2025	4:00:00 PM	0.49
4/1/2025	4:15:00 PM	0.49
4/1/2025	4:30:00 PM	0.5
4/1/2025	4:45:00 PM	0.5
4/1/2025	5:00:00 PM	0.5
4/1/2025	5:15:00 PM	0.5
4/1/2025	5:30:00 PM	0.51
4/1/2025	5:45:00 PM	0.51
4/1/2025	6:00:00 PM	0.51
4/1/2025	6:15:00 PM	0.51
4/1/2025	6:30:00 PM	0.52
4/1/2025	6:45:00 PM	0.52
4/1/2025	7:00:00 PM	0.52
4/1/2025	7:15:00 PM	0.52
4/1/2025	7:30:00 PM	0.52
4/1/2025	7:45:00 PM	0.52
4/1/2025	8:00:00 PM	0.53
4/1/2025	8:15:00 PM	0.53
4/1/2025	8:30:00 PM	0.53
4/1/2025	8:45:00 PM	0.53
4/1/2025	9:00:00 PM	0.53
4/1/2025	9:15:00 PM	0.53
4/1/2025	9:30:00 PM	0.54
4/1/2025	9:45:00 PM	0.54
4/1/2025	10:00:00 PM	0.54
4/1/2025	10:15:00 PM	0.54
4/1/2025	10:30:00 PM	0.54
4/1/2025	10:45:00 PM	0.54

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/1/2025	11:00:00 PM	0.54
4/1/2025	11:15:00 PM	0.54
4/1/2025	11:30:00 PM	0.54
4/1/2025	11:45:00 PM	0.54
4/2/2025	12:00:00 AM	0.54
4/2/2025	12:15:00 AM	0.54
4/2/2025	12:30:00 AM	0.54
4/2/2025	12:45:00 AM	0.54
4/2/2025	1:00:00 AM	0.54
4/2/2025	1:15:00 AM	0.54
4/2/2025	1:30:00 AM	0.54
4/2/2025	1:45:00 AM	0.54
4/2/2025	2:00:00 AM	0.54
4/2/2025	2:15:00 AM	0.54
4/2/2025	2:30:00 AM	0.54
4/2/2025	2:45:00 AM	0.55
4/2/2025	3:00:00 AM	0.55
4/2/2025	3:15:00 AM	0.55
4/2/2025	3:30:00 AM	0.55
4/2/2025	3:45:00 AM	0.55
4/2/2025	4:00:00 AM	0.55
4/2/2025	4:15:00 AM	0.54
4/2/2025	4:30:00 AM	0.54
4/2/2025	4:45:00 AM	0.54
4/2/2025	5:00:00 AM	0.54
4/2/2025	5:15:00 AM	0.54
4/2/2025	5:30:00 AM	0.54
4/2/2025	5:45:00 AM	0.54
4/2/2025	6:00:00 AM	0.55
4/2/2025	6:15:00 AM	0.55
4/2/2025	6:30:00 AM	0.55
4/2/2025	6:45:00 AM	0.54
4/2/2025	7:00:00 AM	0.55
4/2/2025	7:15:00 AM	0.55
4/2/2025	7:30:00 AM	0.55
4/2/2025	7:45:00 AM	0.55
4/2/2025	8:00:00 AM	0.55
4/2/2025	8:15:00 AM	0.54
4/2/2025	8:30:00 AM	0.54
4/2/2025	8:45:00 AM	0.54
4/2/2025	9:00:00 AM	0.54
4/2/2025	9:15:00 AM	0.54
4/2/2025	9:30:00 AM	0.54
4/2/2025	9:45:00 AM	0.54
4/2/2025	10:00:00 AM	0.54
4/2/2025	10:15:00 AM	0.54

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/2/2025	10:30:00 AM	0.54
4/2/2025	10:45:00 AM	0.54
4/2/2025	11:00:00 AM	0.54
4/2/2025	11:15:00 AM	0.54
4/2/2025	11:30:00 AM	0.54
4/2/2025	11:45:00 AM	0.54
4/2/2025	12:00:00 PM	0.54
4/2/2025	12:15:00 PM	0.54
4/2/2025	12:30:00 PM	0.54
4/2/2025	12:45:00 PM	0.54
4/2/2025	1:00:00 PM	0.54
4/2/2025	1:15:00 PM	0.54
4/2/2025	1:30:00 PM	0.54
4/2/2025	1:45:00 PM	0.54
4/2/2025	2:00:00 PM	0.54
4/2/2025	2:15:00 PM	0.54
4/2/2025	2:30:00 PM	0.54
4/2/2025	2:45:00 PM	0.54
4/2/2025	3:00:00 PM	0.54
4/2/2025	3:15:00 PM	0.54
4/2/2025	3:30:00 PM	0.54
4/2/2025	3:45:00 PM	0.54
4/2/2025	4:00:00 PM	0.54
4/2/2025	4:15:00 PM	0.54
4/2/2025	4:30:00 PM	0.54
4/2/2025	4:45:00 PM	0.54
4/2/2025	5:00:00 PM	0.54
4/2/2025	5:15:00 PM	0.53
4/2/2025	5:30:00 PM	0.53
4/2/2025	5:45:00 PM	0.54
4/2/2025	6:00:00 PM	0.53
4/2/2025	6:15:00 PM	0.53
4/2/2025	6:30:00 PM	0.53
4/2/2025	6:45:00 PM	0.54
4/2/2025	7:00:00 PM	0.53
4/2/2025	7:15:00 PM	0.53
4/2/2025	7:30:00 PM	0.54
4/2/2025	7:45:00 PM	0.53
4/2/2025	8:00:00 PM	0.53
4/2/2025	8:15:00 PM	0.53
4/2/2025	8:30:00 PM	0.53
4/2/2025	8:45:00 PM	0.53
4/2/2025	9:00:00 PM	0.53
4/2/2025	9:15:00 PM	0.53
4/2/2025	9:30:00 PM	0.53
4/2/2025	9:45:00 PM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/2/2025	10:00:00 PM	0.53
4/2/2025	10:15:00 PM	0.53
4/2/2025	10:30:00 PM	0.53
4/2/2025	10:45:00 PM	0.53
4/2/2025	11:00:00 PM	0.53
4/2/2025	11:15:00 PM	0.53
4/2/2025	11:30:00 PM	0.53
4/2/2025	11:45:00 PM	0.53
4/3/2025	12:00:00 AM	0.53
4/3/2025	12:15:00 AM	0.53
4/3/2025	12:30:00 AM	0.53
4/3/2025	12:45:00 AM	0.53
4/3/2025	1:00:00 AM	0.53
4/3/2025	1:15:00 AM	0.53
4/3/2025	1:30:00 AM	0.53
4/3/2025	1:45:00 AM	0.53
4/3/2025	2:00:00 AM	0.53
4/3/2025	2:15:00 AM	0.53
4/3/2025	2:30:00 AM	0.53
4/3/2025	2:45:00 AM	0.53
4/3/2025	3:00:00 AM	0.53
4/3/2025	3:15:00 AM	0.53
4/3/2025	3:30:00 AM	0.53
4/3/2025	3:45:00 AM	0.53
4/3/2025	4:00:00 AM	0.53
4/3/2025	4:15:00 AM	0.53
4/3/2025	4:30:00 AM	0.53
4/3/2025	4:45:00 AM	0.53
4/3/2025	5:00:00 AM	0.53
4/3/2025	5:15:00 AM	0.53
4/3/2025	5:30:00 AM	0.53
4/3/2025	5:45:00 AM	0.53
4/3/2025	6:00:00 AM	0.53
4/3/2025	6:15:00 AM	0.53
4/3/2025	6:30:00 AM	0.53
4/3/2025	6:45:00 AM	0.53
4/3/2025	7:00:00 AM	0.53
4/3/2025	7:15:00 AM	0.53
4/3/2025	7:30:00 AM	0.53
4/3/2025	7:45:00 AM	0.53
4/3/2025	8:00:00 AM	0.52
4/3/2025	8:15:00 AM	0.53
4/3/2025	8:30:00 AM	0.53
4/3/2025	8:45:00 AM	0.52
4/3/2025	9:00:00 AM	0.52
4/3/2025	9:15:00 AM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/3/2025	9:30:00 AM	0.52
4/3/2025	9:45:00 AM	0.52
4/3/2025	10:00:00 AM	0.52
4/3/2025	10:15:00 AM	0.51
4/3/2025	10:30:00 AM	0.52
4/3/2025	10:45:00 AM	0.52
4/3/2025	11:00:00 AM	0.52
4/3/2025	11:15:00 AM	0.52
4/3/2025	11:30:00 AM	0.52
4/3/2025	11:45:00 AM	0.51
4/3/2025	12:00:00 PM	0.51
4/3/2025	12:15:00 PM	0.51
4/3/2025	12:30:00 PM	0.51
4/3/2025	12:45:00 PM	0.51
4/3/2025	1:00:00 PM	0.51
4/3/2025	1:15:00 PM	0.51
4/3/2025	1:30:00 PM	0.52
4/3/2025	1:45:00 PM	0.51
4/3/2025	2:00:00 PM	0.51
4/3/2025	2:15:00 PM	0.51
4/3/2025	2:30:00 PM	0.51
4/3/2025	2:45:00 PM	0.51
4/3/2025	3:00:00 PM	0.51
4/3/2025	3:15:00 PM	0.51
4/3/2025	3:30:00 PM	0.51
4/3/2025	3:45:00 PM	0.51
4/3/2025	4:00:00 PM	0.51
4/3/2025	4:15:00 PM	0.51
4/3/2025	4:30:00 PM	0.51
4/3/2025	4:45:00 PM	0.51
4/3/2025	5:00:00 PM	0.51
4/3/2025	5:15:00 PM	0.51
4/3/2025	5:30:00 PM	0.5
4/3/2025	5:45:00 PM	0.5
4/3/2025	6:00:00 PM	0.5
4/3/2025	6:15:00 PM	0.5
4/3/2025	6:30:00 PM	0.5
4/3/2025	6:45:00 PM	0.49
4/3/2025	7:00:00 PM	0.49
4/3/2025	7:15:00 PM	0.49
4/3/2025	7:30:00 PM	0.49
4/3/2025	7:45:00 PM	0.49
4/3/2025	8:00:00 PM	0.49
4/3/2025	8:15:00 PM	0.49
4/3/2025	8:30:00 PM	0.49
4/3/2025	8:45:00 PM	0.49

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/3/2025	9:00:00 PM	0.48
4/3/2025	9:15:00 PM	0.48
4/3/2025	9:30:00 PM	0.48
4/3/2025	9:45:00 PM	0.48
4/3/2025	10:00:00 PM	0.48
4/3/2025	10:15:00 PM	0.48
4/3/2025	10:30:00 PM	0.48
4/3/2025	10:45:00 PM	0.48
4/3/2025	11:00:00 PM	0.48
4/3/2025	11:15:00 PM	0.48
4/3/2025	11:30:00 PM	0.48
4/3/2025	11:45:00 PM	0.47
4/4/2025	12:00:00 AM	0.47
4/4/2025	12:15:00 AM	0.47
4/4/2025	12:30:00 AM	0.47
4/4/2025	12:45:00 AM	0.47
4/4/2025	1:00:00 AM	0.47
4/4/2025	1:15:00 AM	0.47
4/4/2025	1:30:00 AM	0.47
4/4/2025	1:45:00 AM	0.47
4/4/2025	2:00:00 AM	0.47
4/4/2025	2:15:00 AM	0.47
4/4/2025	2:30:00 AM	0.47
4/4/2025	2:45:00 AM	0.47
4/4/2025	3:00:00 AM	0.47
4/4/2025	3:15:00 AM	0.47
4/4/2025	3:30:00 AM	0.47
4/4/2025	3:45:00 AM	0.47
4/4/2025	4:00:00 AM	0.47
4/4/2025	4:15:00 AM	0.47
4/4/2025	4:30:00 AM	0.47
4/4/2025	4:45:00 AM	0.47
4/4/2025	5:00:00 AM	0.47
4/4/2025	5:15:00 AM	0.46
4/4/2025	5:30:00 AM	0.47
4/4/2025	5:45:00 AM	0.47
4/4/2025	6:00:00 AM	0.46
4/4/2025	6:15:00 AM	0.46
4/4/2025	6:30:00 AM	0.46
4/4/2025	6:45:00 AM	0.46
4/4/2025	7:00:00 AM	0.46
4/4/2025	7:15:00 AM	0.46
4/4/2025	7:30:00 AM	0.46
4/4/2025	7:45:00 AM	0.46
4/4/2025	8:00:00 AM	0.46
4/4/2025	8:15:00 AM	0.46

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/4/2025	8:30:00 AM	0.46
4/4/2025	8:45:00 AM	0.46
4/4/2025	9:00:00 AM	0.45
4/4/2025	9:15:00 AM	0.45
4/4/2025	9:30:00 AM	0.45
4/4/2025	9:45:00 AM	0.45
4/4/2025	10:00:00 AM	0.45
4/4/2025	10:15:00 AM	0.45
4/4/2025	10:30:00 AM	0.45
4/4/2025	10:45:00 AM	0.45
4/4/2025	11:00:00 AM	0.45
4/4/2025	11:15:00 AM	0.45
4/4/2025	11:30:00 AM	0.45
4/4/2025	11:45:00 AM	0.45
4/4/2025	12:00:00 PM	0.45
4/4/2025	12:15:00 PM	0.44
4/4/2025	12:30:00 PM	0.44
4/4/2025	12:45:00 PM	0.44
4/4/2025	1:00:00 PM	0.44
4/4/2025	1:15:00 PM	0.44
4/4/2025	1:30:00 PM	0.44
4/4/2025	1:45:00 PM	0.44
4/4/2025	2:00:00 PM	0.44
4/4/2025	2:15:00 PM	0.43
4/4/2025	2:30:00 PM	0.43
4/4/2025	2:45:00 PM	0.43
4/4/2025	3:00:00 PM	0.43
4/4/2025	3:15:00 PM	0.43
4/4/2025	3:30:00 PM	0.43
4/4/2025	3:45:00 PM	0.43
4/4/2025	4:00:00 PM	0.43
4/4/2025	4:15:00 PM	0.43
4/4/2025	4:30:00 PM	0.43
4/4/2025	4:45:00 PM	0.42
4/4/2025	5:00:00 PM	0.42
4/4/2025	5:15:00 PM	0.42
4/4/2025	5:30:00 PM	0.42
4/4/2025	5:45:00 PM	0.42
4/4/2025	6:00:00 PM	0.42
4/4/2025	6:15:00 PM	0.42
4/4/2025	6:30:00 PM	0.42
4/4/2025	6:45:00 PM	0.42
4/4/2025	7:00:00 PM	0.42
4/4/2025	7:15:00 PM	0.42
4/4/2025	7:30:00 PM	0.42
4/4/2025	7:45:00 PM	0.42

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/4/2025	8:00:00 PM	0.42
4/4/2025	8:15:00 PM	0.42
4/4/2025	8:30:00 PM	0.41
4/4/2025	8:45:00 PM	0.41
4/4/2025	9:00:00 PM	0.41
4/4/2025	9:15:00 PM	0.41
4/4/2025	9:30:00 PM	0.41
4/4/2025	9:45:00 PM	0.41
4/4/2025	10:00:00 PM	0.41
4/4/2025	10:15:00 PM	0.41
4/4/2025	10:30:00 PM	0.41
4/4/2025	10:45:00 PM	0.41
4/4/2025	11:00:00 PM	0.41
4/4/2025	11:15:00 PM	0.41
4/4/2025	11:30:00 PM	0.41
4/4/2025	11:45:00 PM	0.41
4/5/2025	12:00:00 AM	0.41
4/5/2025	12:15:00 AM	0.41
4/5/2025	12:30:00 AM	0.41
4/5/2025	12:45:00 AM	0.41
4/5/2025	1:00:00 AM	0.41
4/5/2025	1:15:00 AM	0.41
4/5/2025	1:30:00 AM	0.41
4/5/2025	1:45:00 AM	0.41
4/5/2025	2:00:00 AM	0.41
4/5/2025	2:15:00 AM	0.41
4/5/2025	2:30:00 AM	0.41
4/5/2025	2:45:00 AM	0.42
4/5/2025	3:00:00 AM	0.41
4/5/2025	3:15:00 AM	0.42
4/5/2025	3:30:00 AM	0.42
4/5/2025	3:45:00 AM	0.42
4/5/2025	4:00:00 AM	0.42
4/5/2025	4:15:00 AM	0.42
4/5/2025	4:30:00 AM	0.42
4/5/2025	4:45:00 AM	0.42
4/5/2025	5:00:00 AM	0.42
4/5/2025	5:15:00 AM	0.42
4/5/2025	5:30:00 AM	0.42
4/5/2025	5:45:00 AM	0.42
4/5/2025	6:00:00 AM	0.42
4/5/2025	6:15:00 AM	0.42
4/5/2025	6:30:00 AM	0.42
4/5/2025	6:45:00 AM	0.42
4/5/2025	7:00:00 AM	0.42
4/5/2025	7:15:00 AM	0.42

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/5/2025	7:30:00 AM	0.42
4/5/2025	7:45:00 AM	0.42
4/5/2025	8:00:00 AM	0.42
4/5/2025	8:15:00 AM	0.42
4/5/2025	8:30:00 AM	0.41
4/5/2025	8:45:00 AM	0.41
4/5/2025	9:00:00 AM	0.41
4/5/2025	9:15:00 AM	0.41
4/5/2025	9:30:00 AM	0.41
4/5/2025	9:45:00 AM	0.41
4/5/2025	10:00:00 AM	0.41
4/5/2025	10:15:00 AM	0.42
4/5/2025	10:30:00 AM	0.42
4/5/2025	10:45:00 AM	0.42
4/5/2025	11:00:00 AM	0.42
4/5/2025	11:15:00 AM	0.42
4/5/2025	11:30:00 AM	0.42
4/5/2025	11:45:00 AM	0.42
4/5/2025	12:00:00 PM	0.42
4/5/2025	12:15:00 PM	0.43
4/5/2025	12:30:00 PM	0.43
4/5/2025	12:45:00 PM	0.43
4/5/2025	1:00:00 PM	0.43
4/5/2025	1:15:00 PM	0.43
4/5/2025	1:30:00 PM	0.43
4/5/2025	1:45:00 PM	0.43
4/5/2025	2:00:00 PM	0.44
4/5/2025	2:15:00 PM	0.44
4/5/2025	2:30:00 PM	0.44
4/5/2025	2:45:00 PM	0.44
4/5/2025	3:00:00 PM	0.44
4/5/2025	3:15:00 PM	0.44
4/5/2025	3:30:00 PM	0.44
4/5/2025	3:45:00 PM	0.44
4/5/2025	4:00:00 PM	0.44
4/5/2025	4:15:00 PM	0.44
4/5/2025	4:30:00 PM	0.45
4/5/2025	4:45:00 PM	0.45
4/5/2025	5:00:00 PM	0.45
4/5/2025	5:15:00 PM	0.45
4/5/2025	5:30:00 PM	0.45
4/5/2025	5:45:00 PM	0.45
4/5/2025	6:00:00 PM	0.45
4/5/2025	6:15:00 PM	0.45
4/5/2025	6:30:00 PM	0.45
4/5/2025	6:45:00 PM	0.45

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/5/2025	7:00:00 PM	0.46
4/5/2025	7:15:00 PM	0.46
4/5/2025	7:30:00 PM	0.46
4/5/2025	7:45:00 PM	0.46
4/5/2025	8:00:00 PM	0.46
4/5/2025	8:15:00 PM	0.46
4/5/2025	8:30:00 PM	0.46
4/5/2025	8:45:00 PM	0.46
4/5/2025	9:00:00 PM	0.46
4/5/2025	9:15:00 PM	0.46
4/5/2025	9:30:00 PM	0.46
4/5/2025	9:45:00 PM	0.46
4/5/2025	10:00:00 PM	0.46
4/5/2025	10:15:00 PM	0.46
4/5/2025	10:30:00 PM	0.47
4/5/2025	10:45:00 PM	0.47
4/5/2025	11:00:00 PM	0.47
4/5/2025	11:15:00 PM	0.47
4/5/2025	11:30:00 PM	0.47
4/5/2025	11:45:00 PM	0.47
4/6/2025	12:00:00 AM	0.47
4/6/2025	12:15:00 AM	0.47
4/6/2025	12:30:00 AM	0.47
4/6/2025	12:45:00 AM	0.47
4/6/2025	1:00:00 AM	0.47
4/6/2025	1:15:00 AM	0.47
4/6/2025	1:30:00 AM	0.47
4/6/2025	1:45:00 AM	0.47
4/6/2025	2:00:00 AM	0.47
4/6/2025	2:15:00 AM	0.47
4/6/2025	2:30:00 AM	0.47
4/6/2025	2:45:00 AM	0.47
4/6/2025	3:00:00 AM	0.47
4/6/2025	3:15:00 AM	0.47
4/6/2025	3:30:00 AM	0.47
4/6/2025	3:45:00 AM	0.47
4/6/2025	4:00:00 AM	0.47
4/6/2025	4:15:00 AM	0.47
4/6/2025	4:30:00 AM	0.47
4/6/2025	4:45:00 AM	0.47
4/6/2025	5:00:00 AM	0.47
4/6/2025	5:15:00 AM	0.48
4/6/2025	5:30:00 AM	0.48
4/6/2025	5:45:00 AM	0.48
4/6/2025	6:00:00 AM	0.48
4/6/2025	6:15:00 AM	0.48

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/6/2025	6:30:00 AM	0.48
4/6/2025	6:45:00 AM	0.48
4/6/2025	7:00:00 AM	0.48
4/6/2025	7:15:00 AM	0.48
4/6/2025	7:30:00 AM	0.48
4/6/2025	7:45:00 AM	0.48
4/6/2025	8:00:00 AM	0.48
4/6/2025	8:15:00 AM	0.48
4/6/2025	8:30:00 AM	0.48
4/6/2025	8:45:00 AM	0.48
4/6/2025	9:00:00 AM	0.48
4/6/2025	9:15:00 AM	0.48
4/6/2025	9:30:00 AM	0.48
4/6/2025	9:45:00 AM	0.48
4/6/2025	10:00:00 AM	0.48
4/6/2025	10:15:00 AM	0.48
4/6/2025	10:30:00 AM	0.48
4/6/2025	10:45:00 AM	0.48
4/6/2025	11:00:00 AM	0.48
4/6/2025	11:15:00 AM	0.48
4/6/2025	11:30:00 AM	0.49
4/6/2025	11:45:00 AM	0.49
4/6/2025	12:00:00 PM	0.48
4/6/2025	12:15:00 PM	0.48
4/6/2025	12:30:00 PM	0.49
4/6/2025	12:45:00 PM	0.49
4/6/2025	1:00:00 PM	0.48
4/6/2025	1:15:00 PM	0.48
4/6/2025	1:30:00 PM	0.48
4/6/2025	1:45:00 PM	0.48
4/6/2025	2:00:00 PM	0.49
4/6/2025	2:15:00 PM	0.48
4/6/2025	2:30:00 PM	0.48
4/6/2025	2:45:00 PM	0.48
4/6/2025	3:00:00 PM	0.48
4/6/2025	3:15:00 PM	0.48
4/6/2025	3:30:00 PM	0.48
4/6/2025	3:45:00 PM	0.48
4/6/2025	4:00:00 PM	0.48
4/6/2025	4:15:00 PM	0.48
4/6/2025	4:30:00 PM	0.48
4/6/2025	4:45:00 PM	0.48
4/6/2025	5:00:00 PM	0.48
4/6/2025	5:15:00 PM	0.48
4/6/2025	5:30:00 PM	0.48
4/6/2025	5:45:00 PM	0.48

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/6/2025	6:00:00 PM	0.48
4/6/2025	6:15:00 PM	0.48
4/6/2025	6:30:00 PM	0.48
4/6/2025	6:45:00 PM	0.48
4/6/2025	7:00:00 PM	0.48
4/6/2025	7:15:00 PM	0.48
4/6/2025	7:30:00 PM	0.48
4/6/2025	7:45:00 PM	0.48
4/6/2025	8:00:00 PM	0.48
4/6/2025	8:15:00 PM	0.48
4/6/2025	8:30:00 PM	0.48
4/6/2025	8:45:00 PM	0.48
4/6/2025	9:00:00 PM	0.48
4/6/2025	9:15:00 PM	0.48
4/6/2025	9:30:00 PM	0.48
4/6/2025	9:45:00 PM	0.48
4/6/2025	10:00:00 PM	0.48
4/6/2025	10:15:00 PM	0.48
4/6/2025	10:30:00 PM	0.48
4/6/2025	10:45:00 PM	0.48
4/6/2025	11:00:00 PM	0.48
4/6/2025	11:15:00 PM	0.48
4/6/2025	11:30:00 PM	0.47
4/6/2025	11:45:00 PM	0.47
4/7/2025	12:00:00 AM	0.47
4/7/2025	12:15:00 AM	0.47
4/7/2025	12:30:00 AM	0.47
4/7/2025	12:45:00 AM	0.47
4/7/2025	1:00:00 AM	0.47
4/7/2025	1:15:00 AM	0.47
4/7/2025	1:30:00 AM	0.47
4/7/2025	1:45:00 AM	0.47
4/7/2025	2:00:00 AM	0.47
4/7/2025	2:15:00 AM	0.46
4/7/2025	2:30:00 AM	0.46
4/7/2025	2:45:00 AM	0.46
4/7/2025	3:00:00 AM	0.46
4/7/2025	3:15:00 AM	0.46
4/7/2025	3:30:00 AM	0.46
4/7/2025	3:45:00 AM	0.46
4/7/2025	4:00:00 AM	0.46
4/7/2025	4:15:00 AM	0.46
4/7/2025	4:30:00 AM	0.46
4/7/2025	4:45:00 AM	0.46
4/7/2025	5:00:00 AM	0.46
4/7/2025	5:15:00 AM	0.46

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/7/2025	5:30:00 AM	0.46
4/7/2025	5:45:00 AM	0.46
4/7/2025	6:00:00 AM	0.46
4/7/2025	6:15:00 AM	0.46
4/7/2025	6:30:00 AM	0.46
4/7/2025	6:45:00 AM	0.46
4/7/2025	7:00:00 AM	0.46
4/7/2025	7:15:00 AM	0.46
4/7/2025	7:30:00 AM	0.47
4/7/2025	7:45:00 AM	0.47
4/7/2025	8:00:00 AM	0.47
4/7/2025	8:15:00 AM	0.47
4/7/2025	8:30:00 AM	0.47
4/7/2025	8:45:00 AM	0.47
4/7/2025	9:00:00 AM	0.47
4/7/2025	9:15:00 AM	0.47
4/7/2025	9:30:00 AM	0.47
4/7/2025	9:45:00 AM	0.47
4/7/2025	10:00:00 AM	0.47
4/7/2025	10:15:00 AM	0.47
4/7/2025	10:30:00 AM	0.47
4/7/2025	10:45:00 AM	0.47
4/7/2025	11:00:00 AM	0.47
4/7/2025	11:15:00 AM	0.48
4/7/2025	11:30:00 AM	0.48
4/7/2025	11:45:00 AM	0.48
4/7/2025	12:00:00 PM	0.48
4/7/2025	12:15:00 PM	0.48
4/7/2025	12:30:00 PM	0.48
4/7/2025	12:45:00 PM	0.48
4/7/2025	1:00:00 PM	0.48
4/7/2025	1:15:00 PM	0.48
4/7/2025	1:30:00 PM	0.48
4/7/2025	1:45:00 PM	0.48
4/7/2025	2:00:00 PM	0.48
4/7/2025	2:15:00 PM	0.48
4/7/2025	2:30:00 PM	0.49
4/7/2025	2:45:00 PM	0.48
4/7/2025	3:00:00 PM	0.49
4/7/2025	3:15:00 PM	0.49
4/7/2025	3:30:00 PM	0.49
4/7/2025	3:45:00 PM	0.49
4/7/2025	4:00:00 PM	0.49
4/7/2025	4:15:00 PM	0.49
4/7/2025	4:30:00 PM	0.49
4/7/2025	4:45:00 PM	0.49

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/7/2025	5:00:00 PM	0.49
4/7/2025	5:15:00 PM	0.49
4/7/2025	5:30:00 PM	0.49
4/7/2025	5:45:00 PM	0.49
4/7/2025	6:00:00 PM	0.49
4/7/2025	6:15:00 PM	0.49
4/7/2025	6:30:00 PM	0.49
4/7/2025	6:45:00 PM	0.49
4/7/2025	7:00:00 PM	0.49
4/7/2025	7:15:00 PM	0.49
4/7/2025	7:30:00 PM	0.49
4/7/2025	7:45:00 PM	0.49
4/7/2025	8:00:00 PM	0.49
4/7/2025	8:15:00 PM	0.49
4/7/2025	8:30:00 PM	0.49
4/7/2025	8:45:00 PM	0.49
4/7/2025	9:00:00 PM	0.49
4/7/2025	9:15:00 PM	0.49
4/7/2025	9:30:00 PM	0.49
4/7/2025	9:45:00 PM	0.49
4/7/2025	10:00:00 PM	0.49
4/7/2025	10:15:00 PM	0.49
4/7/2025	10:30:00 PM	0.49
4/7/2025	10:45:00 PM	0.49
4/7/2025	11:00:00 PM	0.49
4/7/2025	11:15:00 PM	0.49
4/7/2025	11:30:00 PM	0.49
4/7/2025	11:45:00 PM	0.49
4/8/2025	12:00:00 AM	0.49
4/8/2025	12:15:00 AM	0.49
4/8/2025	12:30:00 AM	0.49
4/8/2025	12:45:00 AM	0.49
4/8/2025	1:00:00 AM	0.49
4/8/2025	1:15:00 AM	0.49
4/8/2025	1:30:00 AM	0.49
4/8/2025	1:45:00 AM	0.49
4/8/2025	2:00:00 AM	0.5
4/8/2025	2:15:00 AM	0.5
4/8/2025	2:30:00 AM	0.5
4/8/2025	2:45:00 AM	0.5
4/8/2025	3:00:00 AM	0.5
4/8/2025	3:15:00 AM	0.5
4/8/2025	3:30:00 AM	0.5
4/8/2025	3:45:00 AM	0.5
4/8/2025	4:00:00 AM	0.5
4/8/2025	4:15:00 AM	0.5

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/8/2025	4:30:00 AM	0.5
4/8/2025	4:45:00 AM	0.5
4/8/2025	5:00:00 AM	0.5
4/8/2025	5:15:00 AM	0.5
4/8/2025	5:30:00 AM	0.5
4/8/2025	5:45:00 AM	0.5
4/8/2025	6:00:00 AM	0.5
4/8/2025	6:15:00 AM	0.5
4/8/2025	6:30:00 AM	0.5
4/8/2025	6:45:00 AM	0.5
4/8/2025	7:00:00 AM	0.5
4/8/2025	7:15:00 AM	0.5
4/8/2025	7:30:00 AM	0.5
4/8/2025	7:45:00 AM	0.5
4/8/2025	8:00:00 AM	0.5
4/8/2025	8:15:00 AM	0.5
4/8/2025	8:30:00 AM	0.5
4/8/2025	8:45:00 AM	0.5
4/8/2025	9:00:00 AM	0.5
4/8/2025	9:15:00 AM	0.5
4/8/2025	9:30:00 AM	0.5
4/8/2025	9:45:00 AM	0.5
4/8/2025	10:00:00 AM	0.5
4/8/2025	10:15:00 AM	0.5
4/8/2025	10:30:00 AM	0.49
4/8/2025	10:45:00 AM	0.5
4/8/2025	11:00:00 AM	0.5
4/8/2025	11:15:00 AM	0.5
4/8/2025	11:30:00 AM	0.5
4/8/2025	11:45:00 AM	0.5
4/8/2025	12:00:00 PM	0.5
4/8/2025	12:15:00 PM	0.49
4/8/2025	12:30:00 PM	0.5
4/8/2025	12:45:00 PM	0.5
4/8/2025	1:00:00 PM	0.49
4/8/2025	1:15:00 PM	0.5
4/8/2025	1:30:00 PM	0.5
4/8/2025	1:45:00 PM	0.49
4/8/2025	2:00:00 PM	0.5
4/8/2025	2:15:00 PM	0.5
4/8/2025	2:30:00 PM	0.5
4/8/2025	2:45:00 PM	0.49
4/8/2025	3:00:00 PM	0.49
4/8/2025	3:15:00 PM	0.5
4/8/2025	3:30:00 PM	0.49
4/8/2025	3:45:00 PM	0.49

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/8/2025	4:00:00 PM	0.49
4/8/2025	4:15:00 PM	0.49
4/8/2025	4:30:00 PM	0.49
4/8/2025	4:45:00 PM	0.49
4/8/2025	5:00:00 PM	0.49
4/8/2025	5:15:00 PM	0.49
4/8/2025	5:30:00 PM	0.49
4/8/2025	5:45:00 PM	0.49
4/8/2025	6:00:00 PM	0.49
4/8/2025	6:15:00 PM	0.49
4/8/2025	6:30:00 PM	0.49
4/8/2025	6:45:00 PM	0.49
4/8/2025	7:00:00 PM	0.49
4/8/2025	7:15:00 PM	0.49
4/8/2025	7:30:00 PM	0.49
4/8/2025	7:45:00 PM	0.49
4/8/2025	8:00:00 PM	0.49
4/8/2025	8:15:00 PM	0.49
4/8/2025	8:30:00 PM	0.49
4/8/2025	8:45:00 PM	0.49
4/8/2025	9:00:00 PM	0.49
4/8/2025	9:15:00 PM	0.49
4/8/2025	9:30:00 PM	0.49
4/8/2025	9:45:00 PM	0.49
4/8/2025	10:00:00 PM	0.49
4/8/2025	10:15:00 PM	0.49
4/8/2025	10:30:00 PM	0.48
4/8/2025	10:45:00 PM	0.48
4/8/2025	11:00:00 PM	0.48
4/8/2025	11:15:00 PM	0.48
4/8/2025	11:30:00 PM	0.48
4/8/2025	11:45:00 PM	0.48
4/9/2025	12:00:00 AM	0.48
4/9/2025	12:15:00 AM	0.48
4/9/2025	12:30:00 AM	0.48
4/9/2025	12:45:00 AM	0.48
4/9/2025	1:00:00 AM	0.48
4/9/2025	1:15:00 AM	0.47
4/9/2025	1:30:00 AM	0.47
4/9/2025	1:45:00 AM	0.47
4/9/2025	2:00:00 AM	0.47
4/9/2025	2:15:00 AM	0.47
4/9/2025	2:30:00 AM	0.47
4/9/2025	2:45:00 AM	0.47
4/9/2025	3:00:00 AM	0.47
4/9/2025	3:15:00 AM	0.47

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/9/2025	3:30:00 AM	0.47
4/9/2025	3:45:00 AM	0.47
4/9/2025	4:00:00 AM	0.48
4/9/2025	4:15:00 AM	0.48
4/9/2025	4:30:00 AM	0.48
4/9/2025	4:45:00 AM	0.48
4/9/2025	5:00:00 AM	0.48
4/9/2025	5:15:00 AM	0.48
4/9/2025	5:30:00 AM	0.48
4/9/2025	5:45:00 AM	0.48
4/9/2025	6:00:00 AM	0.49
4/9/2025	6:15:00 AM	0.49
4/9/2025	6:30:00 AM	0.49
4/9/2025	6:45:00 AM	0.49
4/9/2025	7:00:00 AM	0.49
4/9/2025	7:15:00 AM	0.49
4/9/2025	7:30:00 AM	0.5
4/9/2025	7:45:00 AM	0.5
4/9/2025	8:00:00 AM	0.5
4/9/2025	8:15:00 AM	0.5
4/9/2025	8:30:00 AM	0.5
4/9/2025	8:45:00 AM	0.5
4/9/2025	9:00:00 AM	0.5
4/9/2025	9:15:00 AM	0.5
4/9/2025	9:30:00 AM	0.5
4/9/2025	9:45:00 AM	0.51
4/9/2025	10:00:00 AM	0.51
4/9/2025	10:15:00 AM	0.51
4/9/2025	10:30:00 AM	0.51
4/9/2025	10:45:00 AM	0.51
4/9/2025	11:00:00 AM	0.51
4/9/2025	11:15:00 AM	0.51
4/9/2025	11:30:00 AM	0.51
4/9/2025	11:45:00 AM	0.51
4/9/2025	12:00:00 PM	0.51
4/9/2025	12:15:00 PM	0.52
4/9/2025	12:30:00 PM	0.52
4/9/2025	12:45:00 PM	0.51
4/9/2025	1:00:00 PM	0.52
4/9/2025	1:15:00 PM	0.52
4/9/2025	1:30:00 PM	0.52
4/9/2025	1:45:00 PM	0.52
4/9/2025	2:00:00 PM	0.52
4/9/2025	2:15:00 PM	0.52
4/9/2025	2:30:00 PM	0.52
4/9/2025	2:45:00 PM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/9/2025	3:00:00 PM	0.52
4/9/2025	3:15:00 PM	0.52
4/9/2025	3:30:00 PM	0.52
4/9/2025	3:45:00 PM	0.52
4/9/2025	4:00:00 PM	0.52
4/9/2025	4:15:00 PM	0.52
4/9/2025	4:30:00 PM	0.52
4/9/2025	4:45:00 PM	0.52
4/9/2025	5:00:00 PM	0.52
4/9/2025	5:15:00 PM	0.52
4/9/2025	5:30:00 PM	0.52
4/9/2025	5:45:00 PM	0.52
4/9/2025	6:00:00 PM	0.52
4/9/2025	6:15:00 PM	0.52
4/9/2025	6:30:00 PM	0.52
4/9/2025	6:45:00 PM	0.52
4/9/2025	7:00:00 PM	0.52
4/9/2025	7:15:00 PM	0.52
4/9/2025	7:30:00 PM	0.52
4/9/2025	7:45:00 PM	0.52
4/9/2025	8:00:00 PM	0.52
4/9/2025	8:15:00 PM	0.52
4/9/2025	8:30:00 PM	0.52
4/9/2025	8:45:00 PM	0.52
4/9/2025	9:00:00 PM	0.52
4/9/2025	9:15:00 PM	0.52
4/9/2025	9:30:00 PM	0.52
4/9/2025	9:45:00 PM	0.52
4/9/2025	10:00:00 PM	0.52
4/9/2025	10:15:00 PM	0.52
4/9/2025	10:30:00 PM	0.52
4/9/2025	10:45:00 PM	0.52
4/9/2025	11:00:00 PM	0.52
4/9/2025	11:15:00 PM	0.52
4/9/2025	11:30:00 PM	0.52
4/9/2025	11:45:00 PM	0.52
4/10/2025	12:00:00 AM	0.52
4/10/2025	12:15:00 AM	0.52
4/10/2025	12:30:00 AM	0.52
4/10/2025	12:45:00 AM	0.52
4/10/2025	1:00:00 AM	0.52
4/10/2025	1:15:00 AM	0.52
4/10/2025	1:30:00 AM	0.52
4/10/2025	1:45:00 AM	0.52
4/10/2025	2:00:00 AM	0.52
4/10/2025	2:15:00 AM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/10/2025	2:30:00 AM	0.52
4/10/2025	2:45:00 AM	0.52
4/10/2025	3:00:00 AM	0.52
4/10/2025	3:15:00 AM	0.52
4/10/2025	3:30:00 AM	0.52
4/10/2025	3:45:00 AM	0.52
4/10/2025	4:00:00 AM	0.52
4/10/2025	4:15:00 AM	0.52
4/10/2025	4:30:00 AM	0.52
4/10/2025	4:45:00 AM	0.52
4/10/2025	5:00:00 AM	0.52
4/10/2025	5:15:00 AM	0.52
4/10/2025	5:30:00 AM	0.52
4/10/2025	5:45:00 AM	0.52
4/10/2025	6:00:00 AM	0.52
4/10/2025	6:15:00 AM	0.52
4/10/2025	6:30:00 AM	0.52
4/10/2025	6:45:00 AM	0.52
4/10/2025	7:00:00 AM	0.52
4/10/2025	7:15:00 AM	0.52
4/10/2025	7:30:00 AM	0.52
4/10/2025	7:45:00 AM	0.52
4/10/2025	8:00:00 AM	0.52
4/10/2025	8:15:00 AM	0.52
4/10/2025	8:30:00 AM	0.52
4/10/2025	8:45:00 AM	0.52
4/10/2025	9:00:00 AM	0.52
4/10/2025	9:15:00 AM	0.52
4/10/2025	9:30:00 AM	0.52
4/10/2025	9:45:00 AM	0.52
4/10/2025	10:00:00 AM	0.52
4/10/2025	10:15:00 AM	0.53
4/10/2025	10:30:00 AM	0.53
4/10/2025	10:45:00 AM	0.53
4/10/2025	11:00:00 AM	0.53
4/10/2025	11:15:00 AM	0.53
4/10/2025	11:30:00 AM	0.53
4/10/2025	11:45:00 AM	0.52
4/10/2025	12:00:00 PM	0.53
4/10/2025	12:15:00 PM	0.53
4/10/2025	12:30:00 PM	0.53
4/10/2025	12:45:00 PM	0.52
4/10/2025	1:00:00 PM	0.53
4/10/2025	1:15:00 PM	0.53
4/10/2025	1:30:00 PM	0.52
4/10/2025	1:45:00 PM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/10/2025	2:00:00 PM	0.52
4/10/2025	2:15:00 PM	0.52
4/10/2025	2:30:00 PM	0.52
4/10/2025	2:45:00 PM	0.52
4/10/2025	3:00:00 PM	0.52
4/10/2025	3:15:00 PM	0.52
4/10/2025	3:30:00 PM	0.52
4/10/2025	3:45:00 PM	0.52
4/10/2025	4:00:00 PM	0.52
4/10/2025	4:15:00 PM	0.52
4/10/2025	4:30:00 PM	0.52
4/10/2025	4:45:00 PM	0.52
4/10/2025	5:00:00 PM	0.52
4/10/2025	5:15:00 PM	0.51
4/10/2025	5:30:00 PM	0.52
4/10/2025	5:45:00 PM	0.52
4/10/2025	6:00:00 PM	0.51
4/10/2025	6:15:00 PM	0.51
4/10/2025	6:30:00 PM	0.51
4/10/2025	6:45:00 PM	0.51
4/10/2025	7:00:00 PM	0.51
4/10/2025	7:15:00 PM	0.51
4/10/2025	7:30:00 PM	0.51
4/10/2025	7:45:00 PM	0.51
4/10/2025	8:00:00 PM	0.52
4/10/2025	8:15:00 PM	0.52
4/10/2025	8:30:00 PM	0.52
4/10/2025	8:45:00 PM	0.52
4/10/2025	9:00:00 PM	0.52
4/10/2025	9:15:00 PM	0.52
4/10/2025	9:30:00 PM	0.52
4/10/2025	9:45:00 PM	0.52
4/10/2025	10:00:00 PM	0.52
4/10/2025	10:15:00 PM	0.52
4/10/2025	10:30:00 PM	0.52
4/10/2025	10:45:00 PM	0.52
4/10/2025	11:00:00 PM	0.52
4/10/2025	11:15:00 PM	0.52
4/10/2025	11:30:00 PM	0.52
4/10/2025	11:45:00 PM	0.52
4/11/2025	12:00:00 AM	0.52
4/11/2025	12:15:00 AM	0.52
4/11/2025	12:30:00 AM	0.52
4/11/2025	12:45:00 AM	0.52
4/11/2025	1:00:00 AM	0.52
4/11/2025	1:15:00 AM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/11/2025	1:30:00 AM	0.52
4/11/2025	1:45:00 AM	0.52
4/11/2025	2:00:00 AM	0.52
4/11/2025	2:15:00 AM	0.52
4/11/2025	2:30:00 AM	0.52
4/11/2025	2:45:00 AM	0.52
4/11/2025	3:00:00 AM	0.52
4/11/2025	3:15:00 AM	0.52
4/11/2025	3:30:00 AM	0.52
4/11/2025	3:45:00 AM	0.52
4/11/2025	4:00:00 AM	0.52
4/11/2025	4:15:00 AM	0.52
4/11/2025	4:30:00 AM	0.52
4/11/2025	4:45:00 AM	0.52
4/11/2025	5:00:00 AM	0.52
4/11/2025	5:15:00 AM	0.52
4/11/2025	5:30:00 AM	0.52
4/11/2025	5:45:00 AM	0.52
4/11/2025	6:00:00 AM	0.52
4/11/2025	6:15:00 AM	0.52
4/11/2025	6:30:00 AM	0.52
4/11/2025	6:45:00 AM	0.52
4/11/2025	7:00:00 AM	0.52
4/11/2025	7:15:00 AM	0.52
4/11/2025	7:30:00 AM	0.52
4/11/2025	7:45:00 AM	0.52
4/11/2025	8:00:00 AM	0.52
4/11/2025	8:15:00 AM	0.52
4/11/2025	8:30:00 AM	0.52
4/11/2025	8:45:00 AM	0.52
4/11/2025	9:00:00 AM	0.52
4/11/2025	9:15:00 AM	0.52
4/11/2025	9:30:00 AM	0.52
4/11/2025	9:45:00 AM	0.52
4/11/2025	10:00:00 AM	0.52
4/11/2025	10:15:00 AM	0.52
4/11/2025	10:30:00 AM	0.52
4/11/2025	10:45:00 AM	0.52
4/11/2025	11:00:00 AM	0.52
4/11/2025	11:15:00 AM	0.52
4/11/2025	11:30:00 AM	0.52
4/11/2025	11:45:00 AM	0.52
4/11/2025	12:00:00 PM	0.52
4/11/2025	12:15:00 PM	0.52
4/11/2025	12:30:00 PM	0.52
4/11/2025	12:45:00 PM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/11/2025	1:00:00 PM	0.52
4/11/2025	1:15:00 PM	0.51
4/11/2025	1:30:00 PM	0.52
4/11/2025	1:45:00 PM	0.52
4/11/2025	2:00:00 PM	0.52
4/11/2025	2:15:00 PM	0.52
4/11/2025	2:30:00 PM	0.51
4/11/2025	2:45:00 PM	0.51
4/11/2025	3:00:00 PM	0.51
4/11/2025	3:15:00 PM	0.51
4/11/2025	3:30:00 PM	0.51
4/11/2025	3:45:00 PM	0.51
4/11/2025	4:00:00 PM	0.51
4/11/2025	4:15:00 PM	0.51
4/11/2025	4:30:00 PM	0.51
4/11/2025	4:45:00 PM	0.51
4/11/2025	5:00:00 PM	0.5
4/11/2025	5:15:00 PM	0.5
4/11/2025	5:30:00 PM	0.5
4/11/2025	5:45:00 PM	0.5
4/11/2025	6:00:00 PM	0.5
4/11/2025	6:15:00 PM	0.5
4/11/2025	6:30:00 PM	0.5
4/11/2025	6:45:00 PM	0.5
4/11/2025	7:00:00 PM	0.5
4/11/2025	7:15:00 PM	0.5
4/11/2025	7:30:00 PM	0.5
4/11/2025	7:45:00 PM	0.5
4/11/2025	8:00:00 PM	0.5
4/11/2025	8:15:00 PM	0.5
4/11/2025	8:30:00 PM	0.5
4/11/2025	8:45:00 PM	0.5
4/11/2025	9:00:00 PM	0.5
4/11/2025	9:15:00 PM	0.51
4/11/2025	9:30:00 PM	0.5
4/11/2025	9:45:00 PM	0.51
4/11/2025	10:00:00 PM	0.51
4/11/2025	10:15:00 PM	0.51
4/11/2025	10:30:00 PM	0.51
4/11/2025	10:45:00 PM	0.51
4/11/2025	11:00:00 PM	0.51
4/11/2025	11:15:00 PM	0.51
4/11/2025	11:30:00 PM	0.51
4/11/2025	11:45:00 PM	0.51
4/12/2025	12:00:00 AM	0.5
4/12/2025	12:15:00 AM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/12/2025	12:30:00 AM	0.51
4/12/2025	12:45:00 AM	0.51
4/12/2025	1:00:00 AM	0.5
4/12/2025	1:15:00 AM	0.5
4/12/2025	1:30:00 AM	0.51
4/12/2025	1:45:00 AM	0.5
4/12/2025	2:00:00 AM	0.5
4/12/2025	2:15:00 AM	0.5
4/12/2025	2:30:00 AM	0.5
4/12/2025	2:45:00 AM	0.5
4/12/2025	3:00:00 AM	0.5
4/12/2025	3:15:00 AM	0.5
4/12/2025	3:30:00 AM	0.5
4/12/2025	3:45:00 AM	0.5
4/12/2025	4:00:00 AM	0.5
4/12/2025	4:15:00 AM	0.5
4/12/2025	4:30:00 AM	0.5
4/12/2025	4:45:00 AM	0.5
4/12/2025	5:00:00 AM	0.5
4/12/2025	5:15:00 AM	0.5
4/12/2025	5:30:00 AM	0.5
4/12/2025	5:45:00 AM	0.5
4/12/2025	6:00:00 AM	0.5
4/12/2025	6:15:00 AM	0.5
4/12/2025	6:30:00 AM	0.5
4/12/2025	6:45:00 AM	0.5
4/12/2025	7:00:00 AM	0.5
4/12/2025	7:15:00 AM	0.5
4/12/2025	7:30:00 AM	0.5
4/12/2025	7:45:00 AM	0.5
4/12/2025	8:00:00 AM	0.5
4/12/2025	8:15:00 AM	0.5
4/12/2025	8:30:00 AM	0.5
4/12/2025	8:45:00 AM	0.5
4/12/2025	9:00:00 AM	0.5
4/12/2025	9:15:00 AM	0.5
4/12/2025	9:30:00 AM	0.5
4/12/2025	9:45:00 AM	0.5
4/12/2025	10:00:00 AM	0.5
4/12/2025	10:15:00 AM	0.5
4/12/2025	10:30:00 AM	0.5
4/12/2025	10:45:00 AM	0.5
4/12/2025	11:00:00 AM	0.5
4/12/2025	11:15:00 AM	0.5
4/12/2025	11:30:00 AM	0.5
4/12/2025	11:45:00 AM	0.5

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/12/2025	12:00:00 PM	0.5
4/12/2025	12:15:00 PM	0.5
4/12/2025	12:30:00 PM	0.5
4/12/2025	12:45:00 PM	0.5
4/12/2025	1:00:00 PM	0.5
4/12/2025	1:15:00 PM	0.49
4/12/2025	1:30:00 PM	0.5
4/12/2025	1:45:00 PM	0.5
4/12/2025	2:00:00 PM	0.5
4/12/2025	2:15:00 PM	0.5
4/12/2025	2:30:00 PM	0.5
4/12/2025	2:45:00 PM	0.49
4/12/2025	3:00:00 PM	0.49
4/12/2025	3:15:00 PM	0.49
4/12/2025	3:30:00 PM	0.49
4/12/2025	3:45:00 PM	0.49
4/12/2025	4:00:00 PM	0.49
4/12/2025	4:15:00 PM	0.48
4/12/2025	4:30:00 PM	0.48
4/12/2025	4:45:00 PM	0.48
4/12/2025	5:00:00 PM	0.48
4/12/2025	5:15:00 PM	0.48
4/12/2025	5:30:00 PM	0.48
4/12/2025	5:45:00 PM	0.48
4/12/2025	6:00:00 PM	0.48
4/12/2025	6:15:00 PM	0.48
4/12/2025	6:30:00 PM	0.48
4/12/2025	6:45:00 PM	0.48
4/12/2025	7:00:00 PM	0.48
4/12/2025	7:15:00 PM	0.48
4/12/2025	7:30:00 PM	0.48
4/12/2025	7:45:00 PM	0.48
4/12/2025	8:00:00 PM	0.48
4/12/2025	8:15:00 PM	0.48
4/12/2025	8:30:00 PM	0.48
4/12/2025	8:45:00 PM	0.48
4/12/2025	9:00:00 PM	0.48
4/12/2025	9:15:00 PM	0.48
4/12/2025	9:30:00 PM	0.48
4/12/2025	9:45:00 PM	0.48
4/12/2025	10:00:00 PM	0.48
4/12/2025	10:15:00 PM	0.48
4/12/2025	10:30:00 PM	0.47
4/12/2025	10:45:00 PM	0.47
4/12/2025	11:00:00 PM	0.47
4/12/2025	11:15:00 PM	0.48

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/12/2025	11:30:00 PM	0.48
4/12/2025	11:45:00 PM	0.48
4/13/2025	12:00:00 AM	0.47
4/13/2025	12:15:00 AM	0.48
4/13/2025	12:30:00 AM	0.47
4/13/2025	12:45:00 AM	0.47
4/13/2025	1:00:00 AM	0.48
4/13/2025	1:15:00 AM	0.48
4/13/2025	1:30:00 AM	0.48
4/13/2025	1:45:00 AM	0.48
4/13/2025	2:00:00 AM	0.48
4/13/2025	2:15:00 AM	0.48
4/13/2025	2:30:00 AM	0.48
4/13/2025	2:45:00 AM	0.48
4/13/2025	3:00:00 AM	0.48
4/13/2025	3:15:00 AM	0.48
4/13/2025	3:30:00 AM	0.48
4/13/2025	3:45:00 AM	0.48
4/13/2025	4:00:00 AM	0.48
4/13/2025	4:15:00 AM	0.48
4/13/2025	4:30:00 AM	0.48
4/13/2025	4:45:00 AM	0.48
4/13/2025	5:00:00 AM	0.48
4/13/2025	5:15:00 AM	0.48
4/13/2025	5:30:00 AM	0.48
4/13/2025	5:45:00 AM	0.48
4/13/2025	6:00:00 AM	0.48
4/13/2025	6:15:00 AM	0.48
4/13/2025	6:30:00 AM	0.49
4/13/2025	6:45:00 AM	0.49
4/13/2025	7:00:00 AM	0.49
4/13/2025	7:15:00 AM	0.49
4/13/2025	7:30:00 AM	0.49
4/13/2025	7:45:00 AM	0.49
4/13/2025	8:00:00 AM	0.49
4/13/2025	8:15:00 AM	0.49
4/13/2025	8:30:00 AM	0.49
4/13/2025	8:45:00 AM	0.49
4/13/2025	9:00:00 AM	0.5
4/13/2025	9:15:00 AM	0.5
4/13/2025	9:30:00 AM	0.5
4/13/2025	9:45:00 AM	0.5
4/13/2025	10:00:00 AM	0.51
4/13/2025	10:15:00 AM	0.51
4/13/2025	10:30:00 AM	0.52
4/13/2025	10:45:00 AM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/13/2025	11:00:00 AM	0.52
4/13/2025	11:15:00 AM	0.53
4/13/2025	11:30:00 AM	0.53
4/13/2025	11:45:00 AM	0.53
4/13/2025	12:00:00 PM	0.53
4/13/2025	12:15:00 PM	0.54
4/13/2025	12:30:00 PM	0.54
4/13/2025	12:45:00 PM	0.54
4/13/2025	1:00:00 PM	0.54
4/13/2025	1:15:00 PM	0.55
4/13/2025	1:30:00 PM	0.55
4/13/2025	1:45:00 PM	0.55
4/13/2025	2:00:00 PM	0.55
4/13/2025	2:15:00 PM	0.55
4/13/2025	2:30:00 PM	0.55
4/13/2025	2:45:00 PM	0.56
4/13/2025	3:00:00 PM	0.56
4/13/2025	3:15:00 PM	0.56
4/13/2025	3:30:00 PM	0.56
4/13/2025	3:45:00 PM	0.56
4/13/2025	4:00:00 PM	0.56
4/13/2025	4:15:00 PM	0.56
4/13/2025	4:30:00 PM	0.57
4/13/2025	4:45:00 PM	0.57
4/13/2025	5:00:00 PM	0.57
4/13/2025	5:15:00 PM	0.57
4/13/2025	5:30:00 PM	0.57
4/13/2025	5:45:00 PM	0.57
4/13/2025	6:00:00 PM	0.57
4/13/2025	6:15:00 PM	0.57
4/13/2025	6:30:00 PM	0.57
4/13/2025	6:45:00 PM	0.57
4/13/2025	7:00:00 PM	0.58
4/13/2025	7:15:00 PM	0.58
4/13/2025	7:30:00 PM	0.58
4/13/2025	7:45:00 PM	0.58
4/13/2025	8:00:00 PM	0.58
4/13/2025	8:15:00 PM	0.58
4/13/2025	8:30:00 PM	0.58
4/13/2025	8:45:00 PM	0.58
4/13/2025	9:00:00 PM	0.59
4/13/2025	9:15:00 PM	0.59
4/13/2025	9:30:00 PM	0.59
4/13/2025	9:45:00 PM	0.59
4/13/2025	10:00:00 PM	0.59
4/13/2025	10:15:00 PM	0.59

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/13/2025	10:30:00 PM	0.59
4/13/2025	10:45:00 PM	0.59
4/13/2025	11:00:00 PM	0.59
4/13/2025	11:15:00 PM	0.59
4/13/2025	11:30:00 PM	0.59
4/13/2025	11:45:00 PM	0.59
4/14/2025	12:00:00 AM	0.59
4/14/2025	12:15:00 AM	0.59
4/14/2025	12:30:00 AM	0.6
4/14/2025	12:45:00 AM	0.59
4/14/2025	1:00:00 AM	0.6
4/14/2025	1:15:00 AM	0.6
4/14/2025	1:30:00 AM	0.6
4/14/2025	1:45:00 AM	0.6
4/14/2025	2:00:00 AM	0.6
4/14/2025	2:15:00 AM	0.6
4/14/2025	2:30:00 AM	0.6
4/14/2025	2:45:00 AM	0.6
4/14/2025	3:00:00 AM	0.6
4/14/2025	3:15:00 AM	0.6
4/14/2025	3:30:00 AM	0.6
4/14/2025	3:45:00 AM	0.6
4/14/2025	4:00:00 AM	0.6
4/14/2025	4:15:00 AM	0.6
4/14/2025	4:30:00 AM	0.6
4/14/2025	4:45:00 AM	0.6
4/14/2025	5:00:00 AM	0.6
4/14/2025	5:15:00 AM	0.6
4/14/2025	5:30:00 AM	0.6
4/14/2025	5:45:00 AM	0.6
4/14/2025	6:00:00 AM	0.6
4/14/2025	6:15:00 AM	0.6
4/14/2025	6:30:00 AM	0.6
4/14/2025	6:45:00 AM	0.6
4/14/2025	7:00:00 AM	0.6
4/14/2025	7:15:00 AM	0.6
4/14/2025	7:30:00 AM	0.59
4/14/2025	7:45:00 AM	0.59
4/14/2025	8:00:00 AM	0.59
4/14/2025	8:15:00 AM	0.59
4/14/2025	8:30:00 AM	0.59
4/14/2025	8:45:00 AM	0.59
4/14/2025	9:00:00 AM	0.59
4/14/2025	9:15:00 AM	0.58
4/14/2025	9:30:00 AM	0.58
4/14/2025	9:45:00 AM	0.58

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/14/2025	10:00:00 AM	0.58
4/14/2025	10:15:00 AM	0.57
4/14/2025	10:30:00 AM	0.57
4/14/2025	10:45:00 AM	0.57
4/14/2025	11:00:00 AM	0.56
4/14/2025	11:15:00 AM	0.56
4/14/2025	11:30:00 AM	0.56
4/14/2025	11:45:00 AM	0.56
4/14/2025	12:00:00 PM	0.56
4/14/2025	12:15:00 PM	0.56
4/14/2025	12:30:00 PM	0.55
4/14/2025	12:45:00 PM	0.55
4/14/2025	1:00:00 PM	0.55
4/14/2025	1:15:00 PM	0.54
4/14/2025	1:30:00 PM	0.54
4/14/2025	1:45:00 PM	0.54
4/14/2025	2:00:00 PM	0.54
4/14/2025	2:15:00 PM	0.54
4/14/2025	2:30:00 PM	0.54
4/14/2025	2:45:00 PM	0.54
4/14/2025	3:00:00 PM	0.53
4/14/2025	3:15:00 PM	0.52
4/14/2025	3:30:00 PM	0.53
4/14/2025	3:45:00 PM	0.52
4/14/2025	4:00:00 PM	0.52
4/14/2025	4:15:00 PM	0.53
4/14/2025	4:30:00 PM	0.52
4/14/2025	4:45:00 PM	0.52
4/14/2025	5:00:00 PM	0.52
4/14/2025	5:15:00 PM	0.52
4/14/2025	5:30:00 PM	0.51
4/14/2025	5:45:00 PM	0.51
4/14/2025	6:00:00 PM	0.51
4/14/2025	6:15:00 PM	0.51
4/14/2025	6:30:00 PM	0.51
4/14/2025	6:45:00 PM	0.51
4/14/2025	7:00:00 PM	0.51
4/14/2025	7:15:00 PM	0.51
4/14/2025	7:30:00 PM	0.51
4/14/2025	7:45:00 PM	0.51
4/14/2025	8:00:00 PM	0.51
4/14/2025	8:15:00 PM	0.51
4/14/2025	8:30:00 PM	0.51
4/14/2025	8:45:00 PM	0.51
4/14/2025	9:00:00 PM	0.51
4/14/2025	9:15:00 PM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/14/2025	9:30:00 PM	0.51
4/14/2025	9:45:00 PM	0.51
4/14/2025	10:00:00 PM	0.51
4/14/2025	10:15:00 PM	0.51
4/14/2025	10:30:00 PM	0.51
4/14/2025	10:45:00 PM	0.51
4/14/2025	11:00:00 PM	0.5
4/14/2025	11:15:00 PM	0.51
4/14/2025	11:30:00 PM	0.5
4/14/2025	11:45:00 PM	0.5
4/15/2025	12:00:00 AM	0.5
4/15/2025	12:15:00 AM	0.5
4/15/2025	12:30:00 AM	0.5
4/15/2025	12:45:00 AM	0.5
4/15/2025	1:00:00 AM	0.5
4/15/2025	1:15:00 AM	0.5
4/15/2025	1:30:00 AM	0.5
4/15/2025	1:45:00 AM	0.5
4/15/2025	2:00:00 AM	0.5
4/15/2025	2:15:00 AM	0.5
4/15/2025	2:30:00 AM	0.5
4/15/2025	2:45:00 AM	0.5
4/15/2025	3:00:00 AM	0.5
4/15/2025	3:15:00 AM	0.5
4/15/2025	3:30:00 AM	0.5
4/15/2025	3:45:00 AM	0.5
4/15/2025	4:00:00 AM	0.5
4/15/2025	4:15:00 AM	0.5
4/15/2025	4:30:00 AM	0.5
4/15/2025	4:45:00 AM	0.5
4/15/2025	5:00:00 AM	0.5
4/15/2025	5:15:00 AM	0.49
4/15/2025	5:30:00 AM	0.49
4/15/2025	5:45:00 AM	0.49
4/15/2025	6:00:00 AM	0.49
4/15/2025	6:15:00 AM	0.49
4/15/2025	6:30:00 AM	0.49
4/15/2025	6:45:00 AM	0.49
4/15/2025	7:00:00 AM	0.49
4/15/2025	7:15:00 AM	0.49
4/15/2025	7:30:00 AM	0.49
4/15/2025	7:45:00 AM	0.49
4/15/2025	8:00:00 AM	0.49
4/15/2025	8:15:00 AM	0.49
4/15/2025	8:30:00 AM	0.49
4/15/2025	8:45:00 AM	0.49

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/15/2025	9:00:00 AM	0.49
4/15/2025	9:15:00 AM	0.49
4/15/2025	9:30:00 AM	0.49
4/15/2025	9:45:00 AM	0.49
4/15/2025	10:00:00 AM	0.49
4/15/2025	10:15:00 AM	0.49
4/15/2025	10:30:00 AM	0.49
4/15/2025	10:45:00 AM	0.49
4/15/2025	11:00:00 AM	0.49
4/15/2025	11:15:00 AM	0.49
4/15/2025	11:30:00 AM	0.49
4/15/2025	11:45:00 AM	0.49
4/15/2025	12:00:00 PM	0.49
4/15/2025	12:15:00 PM	0.48
4/15/2025	12:30:00 PM	0.48
4/15/2025	12:45:00 PM	0.48
4/15/2025	1:00:00 PM	0.48
4/15/2025	1:15:00 PM	0.48
4/15/2025	1:30:00 PM	0.48
4/15/2025	1:45:00 PM	0.48
4/15/2025	2:00:00 PM	0.48
4/15/2025	2:15:00 PM	0.48
4/15/2025	2:30:00 PM	0.48
4/15/2025	2:45:00 PM	0.48
4/15/2025	3:00:00 PM	0.48
4/15/2025	3:15:00 PM	0.48
4/15/2025	3:30:00 PM	0.47
4/15/2025	3:45:00 PM	0.47
4/15/2025	4:00:00 PM	0.47
4/15/2025	4:15:00 PM	0.47
4/15/2025	4:30:00 PM	0.47
4/15/2025	4:45:00 PM	0.47
4/15/2025	5:00:00 PM	0.47
4/15/2025	5:15:00 PM	0.47
4/15/2025	5:30:00 PM	0.47
4/15/2025	5:45:00 PM	0.47
4/15/2025	6:00:00 PM	0.47
4/15/2025	6:15:00 PM	0.47
4/15/2025	6:30:00 PM	0.47
4/15/2025	6:45:00 PM	0.47
4/15/2025	7:00:00 PM	0.47
4/15/2025	7:15:00 PM	0.47
4/15/2025	7:30:00 PM	0.47
4/15/2025	7:45:00 PM	0.47
4/15/2025	8:00:00 PM	0.47
4/15/2025	8:15:00 PM	0.47

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/15/2025	8:30:00 PM	0.47
4/15/2025	8:45:00 PM	0.47
4/15/2025	9:00:00 PM	0.47
4/15/2025	9:15:00 PM	0.47
4/15/2025	9:30:00 PM	0.47
4/15/2025	9:45:00 PM	0.47
4/15/2025	10:00:00 PM	0.47
4/15/2025	10:15:00 PM	0.47
4/15/2025	10:30:00 PM	0.47
4/15/2025	10:45:00 PM	0.47
4/15/2025	11:00:00 PM	0.47
4/15/2025	11:15:00 PM	0.47
4/15/2025	11:30:00 PM	0.47
4/15/2025	11:45:00 PM	0.47
4/16/2025	12:00:00 AM	0.46
4/16/2025	12:15:00 AM	0.46
4/16/2025	12:30:00 AM	0.46
4/16/2025	12:45:00 AM	0.46
4/16/2025	1:00:00 AM	0.46
4/16/2025	1:15:00 AM	0.46
4/16/2025	1:30:00 AM	0.46
4/16/2025	1:45:00 AM	0.46
4/16/2025	2:00:00 AM	0.46
4/16/2025	2:15:00 AM	0.45
4/16/2025	2:30:00 AM	0.45
4/16/2025	2:45:00 AM	0.45
4/16/2025	3:00:00 AM	0.45
4/16/2025	3:15:00 AM	0.45
4/16/2025	3:30:00 AM	0.45
4/16/2025	3:45:00 AM	0.45
4/16/2025	4:00:00 AM	0.45
4/16/2025	4:15:00 AM	0.45
4/16/2025	4:30:00 AM	0.45
4/16/2025	4:45:00 AM	0.45
4/16/2025	5:00:00 AM	0.45
4/16/2025	5:15:00 AM	0.44
4/16/2025	5:30:00 AM	0.44
4/16/2025	5:45:00 AM	0.44
4/16/2025	6:00:00 AM	0.44
4/16/2025	6:15:00 AM	0.44
4/16/2025	6:30:00 AM	0.44
4/16/2025	6:45:00 AM	0.44
4/16/2025	7:00:00 AM	0.44
4/16/2025	7:15:00 AM	0.44
4/16/2025	7:30:00 AM	0.44
4/16/2025	7:45:00 AM	0.44

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/16/2025	8:00:00 AM	0.44
4/16/2025	8:15:00 AM	0.44
4/16/2025	8:30:00 AM	0.44
4/16/2025	8:45:00 AM	0.44
4/16/2025	9:00:00 AM	0.44
4/16/2025	9:15:00 AM	0.44
4/16/2025	9:30:00 AM	0.43
4/16/2025	9:45:00 AM	0.44
4/16/2025	10:00:00 AM	0.44
4/16/2025	10:15:00 AM	0.44
4/16/2025	10:30:00 AM	0.45
4/16/2025	10:45:00 AM	0.46
4/16/2025	11:00:00 AM	0.46
4/16/2025	11:15:00 AM	0.47
4/16/2025	11:30:00 AM	0.47
4/16/2025	11:45:00 AM	0.48
4/16/2025	12:00:00 PM	0.49
4/16/2025	12:15:00 PM	0.5
4/16/2025	12:30:00 PM	0.5
4/16/2025	12:45:00 PM	0.51
4/16/2025	1:00:00 PM	0.51
4/16/2025	1:15:00 PM	0.52
4/16/2025	1:30:00 PM	0.52
4/16/2025	1:45:00 PM	0.53
4/16/2025	2:00:00 PM	0.53
4/16/2025	2:15:00 PM	0.54
4/16/2025	2:30:00 PM	0.54
4/16/2025	2:45:00 PM	0.54
4/16/2025	3:00:00 PM	0.55
4/16/2025	3:15:00 PM	0.55
4/16/2025	3:30:00 PM	0.55
4/16/2025	3:45:00 PM	0.55
4/16/2025	4:00:00 PM	0.56
4/16/2025	4:15:00 PM	0.56
4/16/2025	4:30:00 PM	0.56
4/16/2025	4:45:00 PM	0.57
4/16/2025	5:00:00 PM	0.57
4/16/2025	5:15:00 PM	0.57
4/16/2025	5:30:00 PM	0.57
4/16/2025	5:45:00 PM	0.57
4/16/2025	6:00:00 PM	0.58
4/16/2025	6:15:00 PM	0.58
4/16/2025	6:30:00 PM	0.58
4/16/2025	6:45:00 PM	0.58
4/16/2025	7:00:00 PM	0.58
4/16/2025	7:15:00 PM	0.58

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/16/2025	7:30:00 PM	0.58
4/16/2025	7:45:00 PM	0.59
4/16/2025	8:00:00 PM	0.59
4/16/2025	8:15:00 PM	0.59
4/16/2025	8:30:00 PM	0.59
4/16/2025	8:45:00 PM	0.59
4/16/2025	9:00:00 PM	0.59
4/16/2025	9:15:00 PM	0.59
4/16/2025	9:30:00 PM	0.59
4/16/2025	9:45:00 PM	0.59
4/16/2025	10:00:00 PM	0.59
4/16/2025	10:15:00 PM	0.59
4/16/2025	10:30:00 PM	0.59
4/16/2025	10:45:00 PM	0.59
4/16/2025	11:00:00 PM	0.59
4/16/2025	11:15:00 PM	0.59
4/16/2025	11:30:00 PM	0.59
4/16/2025	11:45:00 PM	0.59
4/17/2025	12:00:00 AM	0.59
4/17/2025	12:15:00 AM	0.59
4/17/2025	12:30:00 AM	0.59
4/17/2025	12:45:00 AM	0.59
4/17/2025	1:00:00 AM	0.59
4/17/2025	1:15:00 AM	0.59
4/17/2025	1:30:00 AM	0.59
4/17/2025	1:45:00 AM	0.59
4/17/2025	2:00:00 AM	0.59
4/17/2025	2:15:00 AM	0.59
4/17/2025	2:30:00 AM	0.59
4/17/2025	2:45:00 AM	0.59
4/17/2025	3:00:00 AM	0.59
4/17/2025	3:15:00 AM	0.59
4/17/2025	3:30:00 AM	0.59
4/17/2025	3:45:00 AM	0.59
4/17/2025	4:00:00 AM	0.59
4/17/2025	4:15:00 AM	0.59
4/17/2025	4:30:00 AM	0.59
4/17/2025	4:45:00 AM	0.59
4/17/2025	5:00:00 AM	0.59
4/17/2025	5:15:00 AM	0.59
4/17/2025	5:30:00 AM	0.59
4/17/2025	5:45:00 AM	0.59
4/17/2025	6:00:00 AM	0.59
4/17/2025	6:15:00 AM	0.59
4/17/2025	6:30:00 AM	0.59
4/17/2025	6:45:00 AM	0.59

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/17/2025	7:00:00 AM	0.59
4/17/2025	7:15:00 AM	0.59
4/17/2025	7:30:00 AM	0.59
4/17/2025	7:45:00 AM	0.59
4/17/2025	8:00:00 AM	0.59
4/17/2025	8:15:00 AM	0.59
4/17/2025	8:30:00 AM	0.59
4/17/2025	8:45:00 AM	0.59
4/17/2025	9:00:00 AM	0.59
4/17/2025	9:15:00 AM	0.59
4/17/2025	9:30:00 AM	0.59
4/17/2025	9:45:00 AM	0.59
4/17/2025	10:00:00 AM	0.58
4/17/2025	10:15:00 AM	0.58
4/17/2025	10:30:00 AM	0.58
4/17/2025	10:45:00 AM	0.58
4/17/2025	11:00:00 AM	0.58
4/17/2025	11:15:00 AM	0.58
4/17/2025	11:30:00 AM	0.58
4/17/2025	11:45:00 AM	0.57
4/17/2025	12:00:00 PM	0.57
4/17/2025	12:15:00 PM	0.57
4/17/2025	12:30:00 PM	0.57
4/17/2025	12:45:00 PM	0.56
4/17/2025	1:00:00 PM	0.56
4/17/2025	1:15:00 PM	0.56
4/17/2025	1:30:00 PM	0.55
4/17/2025	1:45:00 PM	0.55
4/17/2025	2:00:00 PM	0.55
4/17/2025	2:15:00 PM	0.54
4/17/2025	2:30:00 PM	0.54
4/17/2025	2:45:00 PM	0.54
4/17/2025	3:00:00 PM	0.54
4/17/2025	3:15:00 PM	0.53
4/17/2025	3:30:00 PM	0.53
4/17/2025	3:45:00 PM	0.53
4/17/2025	4:00:00 PM	0.53
4/17/2025	4:15:00 PM	0.53
4/17/2025	4:30:00 PM	0.52
4/17/2025	4:45:00 PM	0.52
4/17/2025	5:00:00 PM	0.52
4/17/2025	5:15:00 PM	0.52
4/17/2025	5:30:00 PM	0.52
4/17/2025	5:45:00 PM	0.52
4/17/2025	6:00:00 PM	0.52
4/17/2025	6:15:00 PM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/17/2025	6:30:00 PM	0.51
4/17/2025	6:45:00 PM	0.51
4/17/2025	7:00:00 PM	0.51
4/17/2025	7:15:00 PM	0.51
4/17/2025	7:30:00 PM	0.51
4/17/2025	7:45:00 PM	0.51
4/17/2025	8:00:00 PM	0.5
4/17/2025	8:15:00 PM	0.5
4/17/2025	8:30:00 PM	0.5
4/17/2025	8:45:00 PM	0.5
4/17/2025	9:00:00 PM	0.5
4/17/2025	9:15:00 PM	0.5
4/17/2025	9:30:00 PM	0.5
4/17/2025	9:45:00 PM	0.5
4/17/2025	10:00:00 PM	0.5
4/17/2025	10:15:00 PM	0.5
4/17/2025	10:30:00 PM	0.5
4/17/2025	10:45:00 PM	0.49
4/17/2025	11:00:00 PM	0.49
4/17/2025	11:15:00 PM	0.49
4/17/2025	11:30:00 PM	0.49
4/17/2025	11:45:00 PM	0.49
4/18/2025	12:00:00 AM	0.49
4/18/2025	12:15:00 AM	0.49
4/18/2025	12:30:00 AM	0.49
4/18/2025	12:45:00 AM	0.49
4/18/2025	1:00:00 AM	0.49
4/18/2025	1:15:00 AM	0.48
4/18/2025	1:30:00 AM	0.48
4/18/2025	1:45:00 AM	0.48
4/18/2025	2:00:00 AM	0.48
4/18/2025	2:15:00 AM	0.48
4/18/2025	2:30:00 AM	0.48
4/18/2025	2:45:00 AM	0.48
4/18/2025	3:00:00 AM	0.48
4/18/2025	3:15:00 AM	0.48
4/18/2025	3:30:00 AM	0.48
4/18/2025	3:45:00 AM	0.48
4/18/2025	4:00:00 AM	0.48
4/18/2025	4:15:00 AM	0.48
4/18/2025	4:30:00 AM	0.48
4/18/2025	4:45:00 AM	0.48
4/18/2025	5:00:00 AM	0.47
4/18/2025	5:15:00 AM	0.47
4/18/2025	5:30:00 AM	0.47
4/18/2025	5:45:00 AM	0.47

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/18/2025	6:00:00 AM	0.47
4/18/2025	6:15:00 AM	0.47
4/18/2025	6:30:00 AM	0.47
4/18/2025	6:45:00 AM	0.47
4/18/2025	7:00:00 AM	0.46
4/18/2025	7:15:00 AM	0.46
4/18/2025	7:30:00 AM	0.46
4/18/2025	7:45:00 AM	0.46
4/18/2025	8:00:00 AM	0.46
4/18/2025	8:15:00 AM	0.46
4/18/2025	8:30:00 AM	0.46
4/18/2025	8:45:00 AM	0.45
4/18/2025	9:00:00 AM	0.45
4/18/2025	9:15:00 AM	0.46
4/18/2025	9:30:00 AM	0.45
4/18/2025	9:45:00 AM	0.45
4/18/2025	10:00:00 AM	0.45
4/18/2025	10:15:00 AM	0.45
4/18/2025	10:30:00 AM	0.45
4/18/2025	10:45:00 AM	0.45
4/18/2025	11:00:00 AM	0.45
4/18/2025	11:15:00 AM	0.44
4/18/2025	11:30:00 AM	0.44
4/18/2025	11:45:00 AM	0.44
4/18/2025	12:00:00 PM	0.44
4/18/2025	12:15:00 PM	0.44
4/18/2025	12:30:00 PM	0.44
4/18/2025	12:45:00 PM	0.44
4/18/2025	1:00:00 PM	0.44
4/18/2025	1:15:00 PM	0.44
4/18/2025	1:30:00 PM	0.44
4/18/2025	1:45:00 PM	0.44
4/18/2025	2:00:00 PM	0.44
4/18/2025	2:15:00 PM	0.44
4/18/2025	2:30:00 PM	0.44
4/18/2025	2:45:00 PM	0.44
4/18/2025	3:00:00 PM	0.43
4/18/2025	3:15:00 PM	0.44
4/18/2025	3:30:00 PM	0.43
4/18/2025	3:45:00 PM	0.43
4/18/2025	4:00:00 PM	0.43
4/18/2025	4:15:00 PM	0.43
4/18/2025	4:30:00 PM	0.43
4/18/2025	4:45:00 PM	0.43
4/18/2025	5:00:00 PM	0.43
4/18/2025	5:15:00 PM	0.43

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/18/2025	5:30:00 PM	0.43
4/18/2025	5:45:00 PM	0.43
4/18/2025	6:00:00 PM	0.43
4/18/2025	6:15:00 PM	0.43
4/18/2025	6:30:00 PM	0.43
4/18/2025	6:45:00 PM	0.43
4/18/2025	7:00:00 PM	0.43
4/18/2025	7:15:00 PM	0.43
4/18/2025	7:30:00 PM	0.43
4/18/2025	7:45:00 PM	0.43
4/18/2025	8:00:00 PM	0.43
4/18/2025	8:15:00 PM	0.43
4/18/2025	8:30:00 PM	0.43
4/18/2025	8:45:00 PM	0.43
4/18/2025	9:00:00 PM	0.43
4/18/2025	9:15:00 PM	0.43
4/18/2025	9:30:00 PM	0.42
4/18/2025	9:45:00 PM	0.42
4/18/2025	10:00:00 PM	0.42
4/18/2025	10:15:00 PM	0.42
4/18/2025	10:30:00 PM	0.42
4/18/2025	10:45:00 PM	0.42
4/18/2025	11:00:00 PM	0.42
4/18/2025	11:15:00 PM	0.42
4/18/2025	11:30:00 PM	0.42
4/18/2025	11:45:00 PM	0.42
4/19/2025	12:00:00 AM	0.42
4/19/2025	12:15:00 AM	0.42
4/19/2025	12:30:00 AM	0.42
4/19/2025	12:45:00 AM	0.42
4/19/2025	1:00:00 AM	0.42
4/19/2025	1:15:00 AM	0.42
4/19/2025	1:30:00 AM	0.42
4/19/2025	1:45:00 AM	0.42
4/19/2025	2:00:00 AM	0.42
4/19/2025	2:15:00 AM	0.42
4/19/2025	2:30:00 AM	0.42
4/19/2025	2:45:00 AM	0.42
4/19/2025	3:00:00 AM	0.42
4/19/2025	3:15:00 AM	0.42
4/19/2025	3:30:00 AM	0.42
4/19/2025	3:45:00 AM	0.42
4/19/2025	4:00:00 AM	0.42
4/19/2025	4:15:00 AM	0.42
4/19/2025	4:30:00 AM	0.42
4/19/2025	4:45:00 AM	0.42

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/19/2025	5:00:00 AM	0.42
4/19/2025	5:15:00 AM	0.42
4/19/2025	5:30:00 AM	0.42
4/19/2025	5:45:00 AM	0.42
4/19/2025	6:00:00 AM	0.42
4/19/2025	6:15:00 AM	0.42
4/19/2025	6:30:00 AM	0.42
4/19/2025	6:45:00 AM	0.43
4/19/2025	7:00:00 AM	0.43
4/19/2025	7:15:00 AM	0.43
4/19/2025	7:30:00 AM	0.43
4/19/2025	7:45:00 AM	0.43
4/19/2025	8:00:00 AM	0.43
4/19/2025	8:15:00 AM	0.43
4/19/2025	8:30:00 AM	0.43
4/19/2025	8:45:00 AM	0.43
4/19/2025	9:00:00 AM	0.43
4/19/2025	9:15:00 AM	0.43
4/19/2025	9:30:00 AM	0.43
4/19/2025	9:45:00 AM	0.43
4/19/2025	10:00:00 AM	0.43
4/19/2025	10:15:00 AM	0.43
4/19/2025	10:30:00 AM	0.43
4/19/2025	10:45:00 AM	0.43
4/19/2025	11:00:00 AM	0.44
4/19/2025	11:15:00 AM	0.44
4/19/2025	11:30:00 AM	0.44
4/19/2025	11:45:00 AM	0.44
4/19/2025	12:00:00 PM	0.44
4/19/2025	12:15:00 PM	0.44
4/19/2025	12:30:00 PM	0.44
4/19/2025	12:45:00 PM	0.44
4/19/2025	1:00:00 PM	0.44
4/19/2025	1:15:00 PM	0.44
4/19/2025	1:30:00 PM	0.45
4/19/2025	1:45:00 PM	0.45
4/19/2025	2:00:00 PM	0.45
4/19/2025	2:15:00 PM	0.45
4/19/2025	2:30:00 PM	0.45
4/19/2025	2:45:00 PM	0.45
4/19/2025	3:00:00 PM	0.45
4/19/2025	3:15:00 PM	0.45
4/19/2025	3:30:00 PM	0.45
4/19/2025	3:45:00 PM	0.45
4/19/2025	4:00:00 PM	0.45
4/19/2025	4:15:00 PM	0.46

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/19/2025	4:30:00 PM	0.45
4/19/2025	4:45:00 PM	0.45
4/19/2025	5:00:00 PM	0.45
4/19/2025	5:15:00 PM	0.45
4/19/2025	5:30:00 PM	0.46
4/19/2025	5:45:00 PM	0.45
4/19/2025	6:00:00 PM	0.45
4/19/2025	6:15:00 PM	0.45
4/19/2025	6:30:00 PM	0.45
4/19/2025	6:45:00 PM	0.45
4/19/2025	7:00:00 PM	0.45
4/19/2025	7:15:00 PM	0.45
4/19/2025	7:30:00 PM	0.45
4/19/2025	7:45:00 PM	0.45
4/19/2025	8:00:00 PM	0.46
4/19/2025	8:15:00 PM	0.46
4/19/2025	8:30:00 PM	0.46
4/19/2025	8:45:00 PM	0.46
4/19/2025	9:00:00 PM	0.46
4/19/2025	9:15:00 PM	0.46
4/19/2025	9:30:00 PM	0.46
4/19/2025	9:45:00 PM	0.46
4/19/2025	10:00:00 PM	0.46
4/19/2025	10:15:00 PM	0.46
4/19/2025	10:30:00 PM	0.46
4/19/2025	10:45:00 PM	0.46
4/19/2025	11:00:00 PM	0.46
4/19/2025	11:15:00 PM	0.46
4/19/2025	11:30:00 PM	0.46
4/19/2025	11:45:00 PM	0.46
4/20/2025	12:00:00 AM	0.46
4/20/2025	12:15:00 AM	0.46
4/20/2025	12:30:00 AM	0.46
4/20/2025	12:45:00 AM	0.46
4/20/2025	1:00:00 AM	0.46
4/20/2025	1:15:00 AM	0.46
4/20/2025	1:30:00 AM	0.46
4/20/2025	1:45:00 AM	0.46
4/20/2025	2:00:00 AM	0.46
4/20/2025	2:15:00 AM	0.46
4/20/2025	2:30:00 AM	0.46
4/20/2025	2:45:00 AM	0.46
4/20/2025	3:00:00 AM	0.46
4/20/2025	3:15:00 AM	0.45
4/20/2025	3:30:00 AM	0.45
4/20/2025	3:45:00 AM	0.45

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/20/2025	4:00:00 AM	0.45
4/20/2025	4:15:00 AM	0.45
4/20/2025	4:30:00 AM	0.45
4/20/2025	4:45:00 AM	0.45
4/20/2025	5:00:00 AM	0.45
4/20/2025	5:15:00 AM	0.45
4/20/2025	5:30:00 AM	0.45
4/20/2025	5:45:00 AM	0.45
4/20/2025	6:00:00 AM	0.45
4/20/2025	6:15:00 AM	0.45
4/20/2025	6:30:00 AM	0.45
4/20/2025	6:45:00 AM	0.45
4/20/2025	7:00:00 AM	0.45
4/20/2025	7:15:00 AM	0.45
4/20/2025	7:30:00 AM	0.45
4/20/2025	7:45:00 AM	0.46
4/20/2025	8:00:00 AM	0.46
4/20/2025	8:15:00 AM	0.46
4/20/2025	8:30:00 AM	0.46
4/20/2025	8:45:00 AM	0.46
4/20/2025	9:00:00 AM	0.46
4/20/2025	9:15:00 AM	0.46
4/20/2025	9:30:00 AM	0.46
4/20/2025	9:45:00 AM	0.46
4/20/2025	10:00:00 AM	0.46
4/20/2025	10:15:00 AM	0.46
4/20/2025	10:30:00 AM	0.46
4/20/2025	10:45:00 AM	0.46
4/20/2025	11:00:00 AM	0.46
4/20/2025	11:15:00 AM	0.46
4/20/2025	11:30:00 AM	0.46
4/20/2025	11:45:00 AM	0.47
4/20/2025	12:00:00 PM	0.46
4/20/2025	12:15:00 PM	0.46
4/20/2025	12:30:00 PM	0.47
4/20/2025	12:45:00 PM	0.47
4/20/2025	1:00:00 PM	0.47
4/20/2025	1:15:00 PM	0.47
4/20/2025	1:30:00 PM	0.47
4/20/2025	1:45:00 PM	0.47
4/20/2025	2:00:00 PM	0.47
4/20/2025	2:15:00 PM	0.47
4/20/2025	2:30:00 PM	0.46
4/20/2025	2:45:00 PM	0.47
4/20/2025	3:00:00 PM	0.47
4/20/2025	3:15:00 PM	0.47

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/20/2025	3:30:00 PM	0.46
4/20/2025	3:45:00 PM	0.47
4/20/2025	4:00:00 PM	0.46
4/20/2025	4:15:00 PM	0.46
4/20/2025	4:30:00 PM	0.46
4/20/2025	4:45:00 PM	0.46
4/20/2025	5:00:00 PM	0.46
4/20/2025	5:15:00 PM	0.46
4/20/2025	5:30:00 PM	0.47
4/20/2025	5:45:00 PM	0.47
4/20/2025	6:00:00 PM	0.46
4/20/2025	6:15:00 PM	0.46
4/20/2025	6:30:00 PM	0.46
4/20/2025	6:45:00 PM	0.46
4/20/2025	7:00:00 PM	0.46
4/20/2025	7:15:00 PM	0.47
4/20/2025	7:30:00 PM	0.47
4/20/2025	7:45:00 PM	0.47
4/20/2025	8:00:00 PM	0.47
4/20/2025	8:15:00 PM	0.47
4/20/2025	8:30:00 PM	0.47
4/20/2025	8:45:00 PM	0.47
4/20/2025	9:00:00 PM	0.47
4/20/2025	9:15:00 PM	0.47
4/20/2025	9:30:00 PM	0.46
4/20/2025	9:45:00 PM	0.46
4/20/2025	10:00:00 PM	0.46
4/20/2025	10:15:00 PM	0.46
4/20/2025	10:30:00 PM	0.46
4/20/2025	10:45:00 PM	0.46
4/20/2025	11:00:00 PM	0.46
4/20/2025	11:15:00 PM	0.46
4/20/2025	11:30:00 PM	0.46
4/20/2025	11:45:00 PM	0.46
4/21/2025	12:00:00 AM	0.46
4/21/2025	12:15:00 AM	0.46
4/21/2025	12:30:00 AM	0.46
4/21/2025	12:45:00 AM	0.46
4/21/2025	1:00:00 AM	0.46
4/21/2025	1:15:00 AM	0.47
4/21/2025	1:30:00 AM	0.47
4/21/2025	1:45:00 AM	0.47
4/21/2025	2:00:00 AM	0.47
4/21/2025	2:15:00 AM	0.47
4/21/2025	2:30:00 AM	0.47
4/21/2025	2:45:00 AM	0.47

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/21/2025	3:00:00 AM	0.47
4/21/2025	3:15:00 AM	0.47
4/21/2025	3:30:00 AM	0.48
4/21/2025	3:45:00 AM	0.48
4/21/2025	4:00:00 AM	0.48
4/21/2025	4:15:00 AM	0.48
4/21/2025	4:30:00 AM	0.48
4/21/2025	4:45:00 AM	0.48
4/21/2025	5:00:00 AM	0.48
4/21/2025	5:15:00 AM	0.48
4/21/2025	5:30:00 AM	0.49
4/21/2025	5:45:00 AM	0.49
4/21/2025	6:00:00 AM	0.49
4/21/2025	6:15:00 AM	0.49
4/21/2025	6:30:00 AM	0.49
4/21/2025	6:45:00 AM	0.49
4/21/2025	7:00:00 AM	0.5
4/21/2025	7:15:00 AM	0.5
4/21/2025	7:30:00 AM	0.5
4/21/2025	7:45:00 AM	0.5
4/21/2025	8:00:00 AM	0.5
4/21/2025	8:15:00 AM	0.5
4/21/2025	8:30:00 AM	0.5
4/21/2025	8:45:00 AM	0.5
4/21/2025	9:00:00 AM	0.5
4/21/2025	9:15:00 AM	0.5
4/21/2025	9:30:00 AM	0.51
4/21/2025	9:45:00 AM	0.51
4/21/2025	10:00:00 AM	0.51
4/21/2025	10:15:00 AM	0.51
4/21/2025	10:30:00 AM	0.51
4/21/2025	10:45:00 AM	0.51
4/21/2025	11:00:00 AM	0.51
4/21/2025	11:15:00 AM	0.51
4/21/2025	11:30:00 AM	0.52
4/21/2025	11:45:00 AM	0.52
4/21/2025	12:00:00 PM	0.52
4/21/2025	12:15:00 PM	0.52
4/21/2025	12:30:00 PM	0.52
4/21/2025	12:45:00 PM	0.52
4/21/2025	1:00:00 PM	0.52
4/21/2025	1:15:00 PM	0.52
4/21/2025	1:30:00 PM	0.52
4/21/2025	1:45:00 PM	0.52
4/21/2025	2:00:00 PM	0.52
4/21/2025	2:15:00 PM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/21/2025	2:30:00 PM	0.52
4/21/2025	2:45:00 PM	0.52
4/21/2025	3:00:00 PM	0.52
4/21/2025	3:15:00 PM	0.52
4/21/2025	3:30:00 PM	0.52
4/21/2025	3:45:00 PM	0.52
4/21/2025	4:00:00 PM	0.53
4/21/2025	4:15:00 PM	0.53
4/21/2025	4:30:00 PM	0.53
4/21/2025	4:45:00 PM	0.53
4/21/2025	5:00:00 PM	0.53
4/21/2025	5:15:00 PM	0.53
4/21/2025	5:30:00 PM	0.53
4/21/2025	5:45:00 PM	0.53
4/21/2025	6:00:00 PM	0.53
4/21/2025	6:15:00 PM	0.53
4/21/2025	6:30:00 PM	0.53
4/21/2025	6:45:00 PM	0.53
4/21/2025	7:00:00 PM	0.53
4/21/2025	7:15:00 PM	0.53
4/21/2025	7:30:00 PM	0.53
4/21/2025	7:45:00 PM	0.53
4/21/2025	8:00:00 PM	0.53
4/21/2025	8:15:00 PM	0.53
4/21/2025	8:30:00 PM	0.53
4/21/2025	8:45:00 PM	0.53
4/21/2025	9:00:00 PM	0.53
4/21/2025	9:15:00 PM	0.53
4/21/2025	9:30:00 PM	0.53
4/21/2025	9:45:00 PM	0.53
4/21/2025	10:00:00 PM	0.53
4/21/2025	10:15:00 PM	0.53
4/21/2025	10:30:00 PM	0.53
4/21/2025	10:45:00 PM	0.53
4/21/2025	11:00:00 PM	0.53
4/21/2025	11:15:00 PM	0.52
4/21/2025	11:30:00 PM	0.53
4/21/2025	11:45:00 PM	0.52
4/22/2025	12:00:00 AM	0.52
4/22/2025	12:15:00 AM	0.52
4/22/2025	12:30:00 AM	0.52
4/22/2025	12:45:00 AM	0.52
4/22/2025	1:00:00 AM	0.52
4/22/2025	1:15:00 AM	0.52
4/22/2025	1:30:00 AM	0.52
4/22/2025	1:45:00 AM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/22/2025	2:00:00 AM	0.51
4/22/2025	2:15:00 AM	0.51
4/22/2025	2:30:00 AM	0.51
4/22/2025	2:45:00 AM	0.51
4/22/2025	3:00:00 AM	0.51
4/22/2025	3:15:00 AM	0.51
4/22/2025	3:30:00 AM	0.5
4/22/2025	3:45:00 AM	0.5
4/22/2025	4:00:00 AM	0.5
4/22/2025	4:15:00 AM	0.5
4/22/2025	4:30:00 AM	0.5
4/22/2025	4:45:00 AM	0.5
4/22/2025	5:00:00 AM	0.5
4/22/2025	5:15:00 AM	0.5
4/22/2025	5:30:00 AM	0.5
4/22/2025	5:45:00 AM	0.5
4/22/2025	6:00:00 AM	0.5
4/22/2025	6:15:00 AM	0.5
4/22/2025	6:30:00 AM	0.5
4/22/2025	6:45:00 AM	0.51
4/22/2025	7:00:00 AM	0.51
4/22/2025	7:15:00 AM	0.51
4/22/2025	7:30:00 AM	0.51
4/22/2025	7:45:00 AM	0.51
4/22/2025	8:00:00 AM	0.51
4/22/2025	8:15:00 AM	0.51
4/22/2025	8:30:00 AM	0.51
4/22/2025	8:45:00 AM	0.51
4/22/2025	9:00:00 AM	0.51
4/22/2025	9:15:00 AM	0.51
4/22/2025	9:30:00 AM	0.51
4/22/2025	9:45:00 AM	0.51
4/22/2025	10:00:00 AM	0.51
4/22/2025	10:15:00 AM	0.51
4/22/2025	10:30:00 AM	0.51
4/22/2025	10:45:00 AM	0.52
4/22/2025	11:00:00 AM	0.51
4/22/2025	11:15:00 AM	0.52
4/22/2025	11:30:00 AM	0.52
4/22/2025	11:45:00 AM	0.52
4/22/2025	12:00:00 PM	0.52
4/22/2025	12:15:00 PM	0.52
4/22/2025	12:30:00 PM	0.52
4/22/2025	12:45:00 PM	0.52
4/22/2025	1:00:00 PM	0.52
4/22/2025	1:15:00 PM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/22/2025	1:30:00 PM	0.52
4/22/2025	1:45:00 PM	0.52
4/22/2025	2:00:00 PM	0.51
4/22/2025	2:15:00 PM	0.52
4/22/2025	2:30:00 PM	0.52
4/22/2025	2:45:00 PM	0.52
4/22/2025	3:00:00 PM	0.52
4/22/2025	3:15:00 PM	0.51
4/22/2025	3:30:00 PM	0.52
4/22/2025	3:45:00 PM	0.52
4/22/2025	4:00:00 PM	0.52
4/22/2025	4:15:00 PM	0.51
4/22/2025	4:30:00 PM	0.51
4/22/2025	4:45:00 PM	0.51
4/22/2025	5:00:00 PM	0.51
4/22/2025	5:15:00 PM	0.51
4/22/2025	5:30:00 PM	0.51
4/22/2025	5:45:00 PM	0.51
4/22/2025	6:00:00 PM	0.51
4/22/2025	6:15:00 PM	0.51
4/22/2025	6:30:00 PM	0.51
4/22/2025	6:45:00 PM	0.51
4/22/2025	7:00:00 PM	0.51
4/22/2025	7:15:00 PM	0.51
4/22/2025	7:30:00 PM	0.52
4/22/2025	7:45:00 PM	0.52
4/22/2025	8:00:00 PM	0.52
4/22/2025	8:15:00 PM	0.52
4/22/2025	8:30:00 PM	0.52
4/22/2025	8:45:00 PM	0.52
4/22/2025	9:00:00 PM	0.52
4/22/2025	9:15:00 PM	0.51
4/22/2025	9:30:00 PM	0.51
4/22/2025	9:45:00 PM	0.51
4/22/2025	10:00:00 PM	0.51
4/22/2025	10:15:00 PM	0.51
4/22/2025	10:30:00 PM	0.51
4/22/2025	10:45:00 PM	0.51
4/22/2025	11:00:00 PM	0.51
4/22/2025	11:15:00 PM	0.52
4/22/2025	11:30:00 PM	0.52
4/22/2025	11:45:00 PM	0.52
4/23/2025	12:00:00 AM	0.52
4/23/2025	12:15:00 AM	0.52
4/23/2025	12:30:00 AM	0.52
4/23/2025	12:45:00 AM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/23/2025	1:00:00 AM	0.53
4/23/2025	1:15:00 AM	0.53
4/23/2025	1:30:00 AM	0.53
4/23/2025	1:45:00 AM	0.53
4/23/2025	2:00:00 AM	0.54
4/23/2025	2:15:00 AM	0.54
4/23/2025	2:30:00 AM	0.54
4/23/2025	2:45:00 AM	0.54
4/23/2025	3:00:00 AM	0.54
4/23/2025	3:15:00 AM	0.54
4/23/2025	3:30:00 AM	0.54
4/23/2025	3:45:00 AM	0.54
4/23/2025	4:00:00 AM	0.55
4/23/2025	4:15:00 AM	0.55
4/23/2025	4:30:00 AM	0.55
4/23/2025	4:45:00 AM	0.55
4/23/2025	5:00:00 AM	0.55
4/23/2025	5:15:00 AM	0.55
4/23/2025	5:30:00 AM	0.56
4/23/2025	5:45:00 AM	0.56
4/23/2025	6:00:00 AM	0.56
4/23/2025	6:15:00 AM	0.57
4/23/2025	6:30:00 AM	0.57
4/23/2025	6:45:00 AM	0.57
4/23/2025	7:00:00 AM	0.57
4/23/2025	7:15:00 AM	0.57
4/23/2025	7:30:00 AM	0.58
4/23/2025	7:45:00 AM	0.58
4/23/2025	8:00:00 AM	0.58
4/23/2025	8:15:00 AM	0.59
4/23/2025	8:30:00 AM	0.59
4/23/2025	8:45:00 AM	0.59
4/23/2025	9:00:00 AM	0.59
4/23/2025	9:15:00 AM	0.59
4/23/2025	9:30:00 AM	0.59
4/23/2025	9:45:00 AM	0.59
4/23/2025	10:00:00 AM	0.6
4/23/2025	10:15:00 AM	0.6
4/23/2025	10:30:00 AM	0.6
4/23/2025	10:45:00 AM	0.6
4/23/2025	11:00:00 AM	0.6
4/23/2025	11:15:00 AM	0.6
4/23/2025	11:30:00 AM	0.6
4/23/2025	11:45:00 AM	0.6
4/23/2025	12:00:00 PM	0.6
4/23/2025	12:15:00 PM	0.6

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/23/2025	12:30:00 PM	0.61
4/23/2025	12:45:00 PM	0.6
4/23/2025	1:00:00 PM	0.61
4/23/2025	1:15:00 PM	0.61
4/23/2025	1:30:00 PM	0.61
4/23/2025	1:45:00 PM	0.61
4/23/2025	2:00:00 PM	0.61
4/23/2025	2:15:00 PM	0.61
4/23/2025	2:30:00 PM	0.61
4/23/2025	2:45:00 PM	0.61
4/23/2025	3:00:00 PM	0.61
4/23/2025	3:15:00 PM	0.61
4/23/2025	3:30:00 PM	0.61
4/23/2025	3:45:00 PM	0.61
4/23/2025	4:00:00 PM	0.61
4/23/2025	4:15:00 PM	0.61
4/23/2025	4:30:00 PM	0.61
4/23/2025	4:45:00 PM	0.61
4/23/2025	5:00:00 PM	0.61
4/23/2025	5:15:00 PM	0.61
4/23/2025	5:30:00 PM	0.61
4/23/2025	5:45:00 PM	0.61
4/23/2025	6:00:00 PM	0.61
4/23/2025	6:15:00 PM	0.61
4/23/2025	6:30:00 PM	0.61
4/23/2025	6:45:00 PM	0.61
4/23/2025	7:00:00 PM	0.61
4/23/2025	7:15:00 PM	0.61
4/23/2025	7:30:00 PM	0.61
4/23/2025	7:45:00 PM	0.61
4/23/2025	8:00:00 PM	0.61
4/23/2025	8:15:00 PM	0.61
4/23/2025	8:30:00 PM	0.6
4/23/2025	8:45:00 PM	0.6
4/23/2025	9:00:00 PM	0.6
4/23/2025	9:15:00 PM	0.6
4/23/2025	9:30:00 PM	0.6
4/23/2025	9:45:00 PM	0.6
4/23/2025	10:00:00 PM	0.59
4/23/2025	10:15:00 PM	0.59
4/23/2025	10:30:00 PM	0.59
4/23/2025	10:45:00 PM	0.59
4/23/2025	11:00:00 PM	0.59
4/23/2025	11:15:00 PM	0.59
4/23/2025	11:30:00 PM	0.59
4/23/2025	11:45:00 PM	0.59

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/24/2025	12:00:00 AM	0.59
4/24/2025	12:15:00 AM	0.58
4/24/2025	12:30:00 AM	0.58
4/24/2025	12:45:00 AM	0.58
4/24/2025	1:00:00 AM	0.58
4/24/2025	1:15:00 AM	0.58
4/24/2025	1:30:00 AM	0.58
4/24/2025	1:45:00 AM	0.57
4/24/2025	2:00:00 AM	0.57
4/24/2025	2:15:00 AM	0.57
4/24/2025	2:30:00 AM	0.57
4/24/2025	2:45:00 AM	0.57
4/24/2025	3:00:00 AM	0.57
4/24/2025	3:15:00 AM	0.57
4/24/2025	3:30:00 AM	0.57
4/24/2025	3:45:00 AM	0.57
4/24/2025	4:00:00 AM	0.57
4/24/2025	4:15:00 AM	0.57
4/24/2025	4:30:00 AM	0.57
4/24/2025	4:45:00 AM	0.57
4/24/2025	5:00:00 AM	0.57
4/24/2025	5:15:00 AM	0.57
4/24/2025	5:30:00 AM	0.57
4/24/2025	5:45:00 AM	0.57
4/24/2025	6:00:00 AM	0.57
4/24/2025	6:15:00 AM	0.57
4/24/2025	6:30:00 AM	0.57
4/24/2025	6:45:00 AM	0.57
4/24/2025	7:00:00 AM	0.58
4/24/2025	7:15:00 AM	0.58
4/24/2025	7:30:00 AM	0.58
4/24/2025	7:45:00 AM	0.58
4/24/2025	8:00:00 AM	0.58
4/24/2025	8:15:00 AM	0.58
4/24/2025	8:30:00 AM	0.58
4/24/2025	8:45:00 AM	0.58
4/24/2025	9:00:00 AM	0.58
4/24/2025	9:15:00 AM	0.58
4/24/2025	9:30:00 AM	0.58
4/24/2025	9:45:00 AM	0.58
4/24/2025	10:00:00 AM	0.58
4/24/2025	10:15:00 AM	0.59
4/24/2025	10:30:00 AM	0.59
4/24/2025	10:45:00 AM	0.59
4/24/2025	11:00:00 AM	0.59
4/24/2025	11:15:00 AM	0.59

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/24/2025	11:30:00 AM	0.59
4/24/2025	11:45:00 AM	0.59
4/24/2025	12:00:00 PM	0.59
4/24/2025	12:15:00 PM	0.59
4/24/2025	12:30:00 PM	0.58
4/24/2025	12:45:00 PM	0.58
4/24/2025	1:00:00 PM	0.58
4/24/2025	1:15:00 PM	0.58
4/24/2025	1:30:00 PM	0.59
4/24/2025	1:45:00 PM	0.59
4/24/2025	2:00:00 PM	0.59
4/24/2025	2:15:00 PM	0.6
4/24/2025	2:30:00 PM	0.6
4/24/2025	2:45:00 PM	0.6
4/24/2025	3:00:00 PM	0.6
4/24/2025	3:15:00 PM	0.59
4/24/2025	3:30:00 PM	0.59
4/24/2025	3:45:00 PM	0.59
4/24/2025	4:00:00 PM	0.59
4/24/2025	4:15:00 PM	0.59
4/24/2025	4:30:00 PM	0.58
4/24/2025	4:45:00 PM	0.58
4/24/2025	5:00:00 PM	0.58
4/24/2025	5:15:00 PM	0.58
4/24/2025	5:30:00 PM	0.58
4/24/2025	5:45:00 PM	0.57
4/24/2025	6:00:00 PM	0.57
4/24/2025	6:15:00 PM	0.57
4/24/2025	6:30:00 PM	0.57
4/24/2025	6:45:00 PM	0.57
4/24/2025	7:00:00 PM	0.57
4/24/2025	7:15:00 PM	0.57
4/24/2025	7:30:00 PM	0.57
4/24/2025	7:45:00 PM	0.57
4/24/2025	8:00:00 PM	0.57
4/24/2025	8:15:00 PM	0.57
4/24/2025	8:30:00 PM	0.57
4/24/2025	8:45:00 PM	0.57
4/24/2025	9:00:00 PM	0.57
4/24/2025	9:15:00 PM	0.57
4/24/2025	9:30:00 PM	0.56
4/24/2025	9:45:00 PM	0.57
4/24/2025	10:00:00 PM	0.56
4/24/2025	10:15:00 PM	0.56
4/24/2025	10:30:00 PM	0.56
4/24/2025	10:45:00 PM	0.56

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/24/2025	11:00:00 PM	0.56
4/24/2025	11:15:00 PM	0.56
4/24/2025	11:30:00 PM	0.56
4/24/2025	11:45:00 PM	0.56
4/25/2025	12:00:00 AM	0.56
4/25/2025	12:15:00 AM	0.56
4/25/2025	12:30:00 AM	0.56
4/25/2025	12:45:00 AM	0.56
4/25/2025	1:00:00 AM	0.56
4/25/2025	1:15:00 AM	0.56
4/25/2025	1:30:00 AM	0.56
4/25/2025	1:45:00 AM	0.56
4/25/2025	2:00:00 AM	0.56
4/25/2025	2:15:00 AM	0.56
4/25/2025	2:30:00 AM	0.55
4/25/2025	2:45:00 AM	0.55
4/25/2025	3:00:00 AM	0.55
4/25/2025	3:15:00 AM	0.55
4/25/2025	3:30:00 AM	0.55
4/25/2025	3:45:00 AM	0.55
4/25/2025	4:00:00 AM	0.55
4/25/2025	4:15:00 AM	0.54
4/25/2025	4:30:00 AM	0.54
4/25/2025	4:45:00 AM	0.54
4/25/2025	5:00:00 AM	0.54
4/25/2025	5:15:00 AM	0.54
4/25/2025	5:30:00 AM	0.54
4/25/2025	5:45:00 AM	0.54
4/25/2025	6:00:00 AM	0.54
4/25/2025	6:15:00 AM	0.54
4/25/2025	6:30:00 AM	0.54
4/25/2025	6:45:00 AM	0.54
4/25/2025	7:00:00 AM	0.54
4/25/2025	7:15:00 AM	0.54
4/25/2025	7:30:00 AM	0.54
4/25/2025	7:45:00 AM	0.54
4/25/2025	8:00:00 AM	0.54
4/25/2025	8:15:00 AM	0.54
4/25/2025	8:30:00 AM	0.54
4/25/2025	8:45:00 AM	0.54
4/25/2025	9:00:00 AM	0.54
4/25/2025	9:15:00 AM	0.54
4/25/2025	9:30:00 AM	0.54
4/25/2025	9:45:00 AM	0.54
4/25/2025	10:00:00 AM	0.54
4/25/2025	10:15:00 AM	0.54

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/25/2025	10:30:00 AM	0.54
4/25/2025	10:45:00 AM	0.54
4/25/2025	11:00:00 AM	0.54
4/25/2025	11:15:00 AM	0.53
4/25/2025	11:30:00 AM	0.54
4/25/2025	11:45:00 AM	0.54
4/25/2025	12:00:00 PM	0.53
4/25/2025	12:15:00 PM	0.54
4/25/2025	12:30:00 PM	0.54
4/25/2025	12:45:00 PM	0.53
4/25/2025	1:00:00 PM	0.54
4/25/2025	1:15:00 PM	0.53
4/25/2025	1:30:00 PM	0.53
4/25/2025	1:45:00 PM	0.53
4/25/2025	2:00:00 PM	0.53
4/25/2025	2:15:00 PM	0.53
4/25/2025	2:30:00 PM	0.53
4/25/2025	2:45:00 PM	0.53
4/25/2025	3:00:00 PM	0.53
4/25/2025	3:15:00 PM	0.52
4/25/2025	3:30:00 PM	0.51
4/25/2025	3:45:00 PM	0.5
4/25/2025	4:00:00 PM	0.5
4/25/2025	4:15:00 PM	0.5
4/25/2025	4:30:00 PM	0.5
4/25/2025	4:45:00 PM	0.5
4/25/2025	5:00:00 PM	0.5
4/25/2025	5:15:00 PM	0.49
4/25/2025	5:30:00 PM	0.49
4/25/2025	5:45:00 PM	0.49
4/25/2025	6:00:00 PM	0.49
4/25/2025	6:15:00 PM	0.49
4/25/2025	6:30:00 PM	0.49
4/25/2025	6:45:00 PM	0.49
4/25/2025	7:00:00 PM	0.49
4/25/2025	7:15:00 PM	0.49
4/25/2025	7:30:00 PM	0.49
4/25/2025	7:45:00 PM	0.49
4/25/2025	8:00:00 PM	0.49
4/25/2025	8:15:00 PM	0.49
4/25/2025	8:30:00 PM	0.49
4/25/2025	8:45:00 PM	0.49
4/25/2025	9:00:00 PM	0.49
4/25/2025	9:15:00 PM	0.49
4/25/2025	9:30:00 PM	0.49
4/25/2025	9:45:00 PM	0.49

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/25/2025	10:00:00 PM	0.49
4/25/2025	10:15:00 PM	0.49
4/25/2025	10:30:00 PM	0.49
4/25/2025	10:45:00 PM	0.5
4/25/2025	11:00:00 PM	0.5
4/25/2025	11:15:00 PM	0.5
4/25/2025	11:30:00 PM	0.5
4/25/2025	11:45:00 PM	0.5
4/26/2025	12:00:00 AM	0.5
4/26/2025	12:15:00 AM	0.5
4/26/2025	12:30:00 AM	0.5
4/26/2025	12:45:00 AM	0.5
4/26/2025	1:00:00 AM	0.5
4/26/2025	1:15:00 AM	0.5
4/26/2025	1:30:00 AM	0.5
4/26/2025	1:45:00 AM	0.5
4/26/2025	2:00:00 AM	0.5
4/26/2025	2:15:00 AM	0.5
4/26/2025	2:30:00 AM	0.5
4/26/2025	2:45:00 AM	0.5
4/26/2025	3:00:00 AM	0.5
4/26/2025	3:15:00 AM	0.5
4/26/2025	3:30:00 AM	0.5
4/26/2025	3:45:00 AM	0.5
4/26/2025	4:00:00 AM	0.5
4/26/2025	4:15:00 AM	0.5
4/26/2025	4:30:00 AM	0.5
4/26/2025	4:45:00 AM	0.5
4/26/2025	5:00:00 AM	0.5
4/26/2025	5:15:00 AM	0.5
4/26/2025	5:30:00 AM	0.5
4/26/2025	5:45:00 AM	0.5
4/26/2025	6:00:00 AM	0.5
4/26/2025	6:15:00 AM	0.5
4/26/2025	6:30:00 AM	0.51
4/26/2025	6:45:00 AM	0.5
4/26/2025	7:00:00 AM	0.51
4/26/2025	7:15:00 AM	0.5
4/26/2025	7:30:00 AM	0.5
4/26/2025	7:45:00 AM	0.51
4/26/2025	8:00:00 AM	0.51
4/26/2025	8:15:00 AM	0.51
4/26/2025	8:30:00 AM	0.51
4/26/2025	8:45:00 AM	0.51
4/26/2025	9:00:00 AM	0.51
4/26/2025	9:15:00 AM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/26/2025	9:30:00 AM	0.53
4/26/2025	9:45:00 AM	0.53
4/26/2025	10:00:00 AM	0.53
4/26/2025	10:15:00 AM	0.53
4/26/2025	10:30:00 AM	0.53
4/26/2025	10:45:00 AM	0.52
4/26/2025	11:00:00 AM	0.52
4/26/2025	11:15:00 AM	0.52
4/26/2025	11:30:00 AM	0.52
4/26/2025	11:45:00 AM	0.52
4/26/2025	12:00:00 PM	0.52
4/26/2025	12:15:00 PM	0.52
4/26/2025	12:30:00 PM	0.52
4/26/2025	12:45:00 PM	0.51
4/26/2025	1:00:00 PM	0.52
4/26/2025	1:15:00 PM	0.51
4/26/2025	1:30:00 PM	0.51
4/26/2025	1:45:00 PM	0.51
4/26/2025	2:00:00 PM	0.51
4/26/2025	2:15:00 PM	0.51
4/26/2025	2:30:00 PM	0.51
4/26/2025	2:45:00 PM	0.51
4/26/2025	3:00:00 PM	0.52
4/26/2025	3:15:00 PM	0.51
4/26/2025	3:30:00 PM	0.51
4/26/2025	3:45:00 PM	0.51
4/26/2025	4:00:00 PM	0.51
4/26/2025	4:15:00 PM	0.51
4/26/2025	4:30:00 PM	0.51
4/26/2025	4:45:00 PM	0.51
4/26/2025	5:00:00 PM	0.51
4/26/2025	5:15:00 PM	0.51
4/26/2025	5:30:00 PM	0.51
4/26/2025	5:45:00 PM	0.51
4/26/2025	6:00:00 PM	0.51
4/26/2025	6:15:00 PM	0.51
4/26/2025	6:30:00 PM	0.51
4/26/2025	6:45:00 PM	0.51
4/26/2025	7:00:00 PM	0.51
4/26/2025	7:15:00 PM	0.51
4/26/2025	7:30:00 PM	0.51
4/26/2025	7:45:00 PM	0.51
4/26/2025	8:00:00 PM	0.51
4/26/2025	8:15:00 PM	0.51
4/26/2025	8:30:00 PM	0.51
4/26/2025	8:45:00 PM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/26/2025	9:00:00 PM	0.51
4/26/2025	9:15:00 PM	0.51
4/26/2025	9:30:00 PM	0.51
4/26/2025	9:45:00 PM	0.51
4/26/2025	10:00:00 PM	0.51
4/26/2025	10:15:00 PM	0.51
4/26/2025	10:30:00 PM	0.51
4/26/2025	10:45:00 PM	0.51
4/26/2025	11:00:00 PM	0.51
4/26/2025	11:15:00 PM	0.51
4/26/2025	11:30:00 PM	0.51
4/26/2025	11:45:00 PM	0.51
4/27/2025	12:00:00 AM	0.51
4/27/2025	12:15:00 AM	0.51
4/27/2025	12:30:00 AM	0.51
4/27/2025	12:45:00 AM	0.51
4/27/2025	1:00:00 AM	0.51
4/27/2025	1:15:00 AM	0.51
4/27/2025	1:30:00 AM	0.51
4/27/2025	1:45:00 AM	0.51
4/27/2025	2:00:00 AM	0.51
4/27/2025	2:15:00 AM	0.51
4/27/2025	2:30:00 AM	0.51
4/27/2025	2:45:00 AM	0.51
4/27/2025	3:00:00 AM	0.51
4/27/2025	3:15:00 AM	0.51
4/27/2025	3:30:00 AM	0.51
4/27/2025	3:45:00 AM	0.51
4/27/2025	4:00:00 AM	0.51
4/27/2025	4:15:00 AM	0.51
4/27/2025	4:30:00 AM	0.51
4/27/2025	4:45:00 AM	0.52
4/27/2025	5:00:00 AM	0.52
4/27/2025	5:15:00 AM	0.51
4/27/2025	5:30:00 AM	0.51
4/27/2025	5:45:00 AM	0.51
4/27/2025	6:00:00 AM	0.51
4/27/2025	6:15:00 AM	0.52
4/27/2025	6:30:00 AM	0.52
4/27/2025	6:45:00 AM	0.52
4/27/2025	7:00:00 AM	0.52
4/27/2025	7:15:00 AM	0.51
4/27/2025	7:30:00 AM	0.52
4/27/2025	7:45:00 AM	0.52
4/27/2025	8:00:00 AM	0.52
4/27/2025	8:15:00 AM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/27/2025	8:30:00 AM	0.52
4/27/2025	8:45:00 AM	0.52
4/27/2025	9:00:00 AM	0.52
4/27/2025	9:15:00 AM	0.52
4/27/2025	9:30:00 AM	0.52
4/27/2025	9:45:00 AM	0.52
4/27/2025	10:00:00 AM	0.51
4/27/2025	10:15:00 AM	0.52
4/27/2025	10:30:00 AM	0.52
4/27/2025	10:45:00 AM	0.52
4/27/2025	11:00:00 AM	0.52
4/27/2025	11:15:00 AM	0.52
4/27/2025	11:30:00 AM	0.52
4/27/2025	11:45:00 AM	0.52
4/27/2025	12:00:00 PM	0.52
4/27/2025	12:15:00 PM	0.52
4/27/2025	12:30:00 PM	0.52
4/27/2025	12:45:00 PM	0.52
4/27/2025	1:00:00 PM	0.52
4/27/2025	1:15:00 PM	0.52
4/27/2025	1:30:00 PM	0.52
4/27/2025	1:45:00 PM	0.51
4/27/2025	2:00:00 PM	0.52
4/27/2025	2:15:00 PM	0.51
4/27/2025	2:30:00 PM	0.51
4/27/2025	2:45:00 PM	0.51
4/27/2025	3:00:00 PM	0.51
4/27/2025	3:15:00 PM	0.51
4/27/2025	3:30:00 PM	0.51
4/27/2025	3:45:00 PM	0.51
4/27/2025	4:00:00 PM	0.51
4/27/2025	4:15:00 PM	0.51
4/27/2025	4:30:00 PM	0.51
4/27/2025	4:45:00 PM	0.51
4/27/2025	5:00:00 PM	0.51
4/27/2025	5:15:00 PM	0.51
4/27/2025	5:30:00 PM	0.51
4/27/2025	5:45:00 PM	0.51
4/27/2025	6:00:00 PM	0.51
4/27/2025	6:15:00 PM	0.51
4/27/2025	6:30:00 PM	0.51
4/27/2025	6:45:00 PM	0.51
4/27/2025	7:00:00 PM	0.51
4/27/2025	7:15:00 PM	0.51
4/27/2025	7:30:00 PM	0.51
4/27/2025	7:45:00 PM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/27/2025	8:00:00 PM	0.51
4/27/2025	8:15:00 PM	0.51
4/27/2025	8:30:00 PM	0.51
4/27/2025	8:45:00 PM	0.51
4/27/2025	9:00:00 PM	0.51
4/27/2025	9:15:00 PM	0.51
4/27/2025	9:30:00 PM	0.51
4/27/2025	9:45:00 PM	0.51
4/27/2025	10:00:00 PM	0.51
4/27/2025	10:15:00 PM	0.51
4/27/2025	10:30:00 PM	0.51
4/27/2025	10:45:00 PM	0.51
4/27/2025	11:00:00 PM	0.5
4/27/2025	11:15:00 PM	0.5
4/27/2025	11:30:00 PM	0.5
4/27/2025	11:45:00 PM	0.5
4/28/2025	12:00:00 AM	0.5
4/28/2025	12:15:00 AM	0.5
4/28/2025	12:30:00 AM	0.5
4/28/2025	12:45:00 AM	0.5
4/28/2025	1:00:00 AM	0.5
4/28/2025	1:15:00 AM	0.5
4/28/2025	1:30:00 AM	0.5
4/28/2025	1:45:00 AM	0.5
4/28/2025	2:00:00 AM	0.5
4/28/2025	2:15:00 AM	0.5
4/28/2025	2:30:00 AM	0.5
4/28/2025	2:45:00 AM	0.5
4/28/2025	3:00:00 AM	0.5
4/28/2025	3:15:00 AM	0.5
4/28/2025	3:30:00 AM	0.5
4/28/2025	3:45:00 AM	0.5
4/28/2025	4:00:00 AM	0.5
4/28/2025	4:15:00 AM	0.5
4/28/2025	4:30:00 AM	0.5
4/28/2025	4:45:00 AM	0.5
4/28/2025	5:00:00 AM	0.5
4/28/2025	5:15:00 AM	0.5
4/28/2025	5:30:00 AM	0.5
4/28/2025	5:45:00 AM	0.5
4/28/2025	6:00:00 AM	0.5
4/28/2025	6:15:00 AM	0.5
4/28/2025	6:30:00 AM	0.5
4/28/2025	6:45:00 AM	0.5
4/28/2025	7:00:00 AM	0.5
4/28/2025	7:15:00 AM	0.5

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/28/2025	7:30:00 AM	0.5
4/28/2025	7:45:00 AM	0.5
4/28/2025	8:00:00 AM	0.5
4/28/2025	8:15:00 AM	0.5
4/28/2025	8:30:00 AM	0.5
4/28/2025	8:45:00 AM	0.5
4/28/2025	9:00:00 AM	0.5
4/28/2025	9:15:00 AM	0.5
4/28/2025	9:30:00 AM	0.5
4/28/2025	9:45:00 AM	0.5
4/28/2025	10:00:00 AM	0.5
4/28/2025	10:15:00 AM	0.5
4/28/2025	10:30:00 AM	0.5
4/28/2025	10:45:00 AM	0.5
4/28/2025	11:00:00 AM	0.49
4/28/2025	11:15:00 AM	0.5
4/28/2025	11:30:00 AM	0.49
4/28/2025	11:45:00 AM	0.49
4/28/2025	12:00:00 PM	0.49
4/28/2025	12:15:00 PM	0.49
4/28/2025	12:30:00 PM	0.49
4/28/2025	12:45:00 PM	0.49
4/28/2025	1:00:00 PM	0.49
4/28/2025	1:15:00 PM	0.49
4/28/2025	1:30:00 PM	0.49
4/28/2025	1:45:00 PM	0.49
4/28/2025	2:00:00 PM	0.49
4/28/2025	2:15:00 PM	0.49
4/28/2025	2:30:00 PM	0.49
4/28/2025	2:45:00 PM	0.49
4/28/2025	3:00:00 PM	0.49
4/28/2025	3:15:00 PM	0.49
4/28/2025	3:30:00 PM	0.49
4/28/2025	3:45:00 PM	0.48
4/28/2025	4:00:00 PM	0.48
4/28/2025	4:15:00 PM	0.48
4/28/2025	4:30:00 PM	0.48
4/28/2025	4:45:00 PM	0.48
4/28/2025	5:00:00 PM	0.48
4/28/2025	5:15:00 PM	0.48
4/28/2025	5:30:00 PM	0.48
4/28/2025	5:45:00 PM	0.48
4/28/2025	6:00:00 PM	0.48
4/28/2025	6:15:00 PM	0.48
4/28/2025	6:30:00 PM	0.48
4/28/2025	6:45:00 PM	0.48

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/28/2025	7:00:00 PM	0.48
4/28/2025	7:15:00 PM	0.48
4/28/2025	7:30:00 PM	0.47
4/28/2025	7:45:00 PM	0.48
4/28/2025	8:00:00 PM	0.47
4/28/2025	8:15:00 PM	0.47
4/28/2025	8:30:00 PM	0.47
4/28/2025	8:45:00 PM	0.47
4/28/2025	9:00:00 PM	0.47
4/28/2025	9:15:00 PM	0.47
4/28/2025	9:30:00 PM	0.47
4/28/2025	9:45:00 PM	0.46
4/28/2025	10:00:00 PM	0.46
4/28/2025	10:15:00 PM	0.46
4/28/2025	10:30:00 PM	0.46
4/28/2025	10:45:00 PM	0.46
4/28/2025	11:00:00 PM	0.46
4/28/2025	11:15:00 PM	0.46
4/28/2025	11:30:00 PM	0.46
4/28/2025	11:45:00 PM	0.46
4/29/2025	12:00:00 AM	0.46
4/29/2025	12:15:00 AM	0.46
4/29/2025	12:30:00 AM	0.47
4/29/2025	12:45:00 AM	0.47
4/29/2025	1:00:00 AM	0.47
4/29/2025	1:15:00 AM	0.47
4/29/2025	1:30:00 AM	0.47
4/29/2025	1:45:00 AM	0.47
4/29/2025	2:00:00 AM	0.47
4/29/2025	2:15:00 AM	0.47
4/29/2025	2:30:00 AM	0.47
4/29/2025	2:45:00 AM	0.48
4/29/2025	3:00:00 AM	0.48
4/29/2025	3:15:00 AM	0.48
4/29/2025	3:30:00 AM	0.48
4/29/2025	3:45:00 AM	0.48
4/29/2025	4:00:00 AM	0.48
4/29/2025	4:15:00 AM	0.48
4/29/2025	4:30:00 AM	0.48
4/29/2025	4:45:00 AM	0.47
4/29/2025	5:00:00 AM	0.47
4/29/2025	5:15:00 AM	0.47
4/29/2025	5:30:00 AM	0.47
4/29/2025	5:45:00 AM	0.47
4/29/2025	6:00:00 AM	0.46
4/29/2025	6:15:00 AM	0.46

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/29/2025	6:30:00 AM	0.46
4/29/2025	6:45:00 AM	0.46
4/29/2025	7:00:00 AM	0.45
4/29/2025	7:15:00 AM	0.45
4/29/2025	7:30:00 AM	0.45
4/29/2025	7:45:00 AM	0.45
4/29/2025	8:00:00 AM	0.44
4/29/2025	8:15:00 AM	0.44
4/29/2025	8:30:00 AM	0.44
4/29/2025	8:45:00 AM	0.44
4/29/2025	9:00:00 AM	0.43
4/29/2025	9:15:00 AM	0.43
4/29/2025	9:30:00 AM	0.43
4/29/2025	9:45:00 AM	0.43
4/29/2025	10:00:00 AM	0.43
4/29/2025	10:15:00 AM	0.43
4/29/2025	10:30:00 AM	0.43
4/29/2025	10:45:00 AM	0.43
4/29/2025	11:00:00 AM	0.43
4/29/2025	11:15:00 AM	0.43
4/29/2025	11:30:00 AM	0.44
4/29/2025	11:45:00 AM	0.44
4/29/2025	12:00:00 PM	0.44
4/29/2025	12:15:00 PM	0.45
4/29/2025	12:30:00 PM	0.45
4/29/2025	12:45:00 PM	0.46
4/29/2025	1:00:00 PM	0.46
4/29/2025	1:15:00 PM	0.46
4/29/2025	1:30:00 PM	0.47
4/29/2025	1:45:00 PM	0.47
4/29/2025	2:00:00 PM	0.47
4/29/2025	2:15:00 PM	0.48
4/29/2025	2:30:00 PM	0.48
4/29/2025	2:45:00 PM	0.48
4/29/2025	3:00:00 PM	0.48
4/29/2025	3:15:00 PM	0.48
4/29/2025	3:30:00 PM	0.49
4/29/2025	3:45:00 PM	0.49
4/29/2025	4:00:00 PM	0.49
4/29/2025	4:15:00 PM	0.49
4/29/2025	4:30:00 PM	0.49
4/29/2025	4:45:00 PM	0.49
4/29/2025	5:00:00 PM	0.49
4/29/2025	5:15:00 PM	0.5
4/29/2025	5:30:00 PM	0.5
4/29/2025	5:45:00 PM	0.5

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/29/2025	6:00:00 PM	0.5
4/29/2025	6:15:00 PM	0.5
4/29/2025	6:30:00 PM	0.5
4/29/2025	6:45:00 PM	0.5
4/29/2025	7:00:00 PM	0.5
4/29/2025	7:15:00 PM	0.5
4/29/2025	7:30:00 PM	0.5
4/29/2025	7:45:00 PM	0.5
4/29/2025	8:00:00 PM	0.5
4/29/2025	8:15:00 PM	0.51
4/29/2025	8:30:00 PM	0.51
4/29/2025	8:45:00 PM	0.51
4/29/2025	9:00:00 PM	0.51
4/29/2025	9:15:00 PM	0.51
4/29/2025	9:30:00 PM	0.51
4/29/2025	9:45:00 PM	0.51
4/29/2025	10:00:00 PM	0.51
4/29/2025	10:15:00 PM	0.51
4/29/2025	10:30:00 PM	0.51
4/29/2025	10:45:00 PM	0.51
4/29/2025	11:00:00 PM	0.51
4/29/2025	11:15:00 PM	0.52
4/29/2025	11:30:00 PM	0.52
4/29/2025	11:45:00 PM	0.52
4/30/2025	12:00:00 AM	0.52
4/30/2025	12:15:00 AM	0.52
4/30/2025	12:30:00 AM	0.52
4/30/2025	12:45:00 AM	0.52
4/30/2025	1:00:00 AM	0.52
4/30/2025	1:15:00 AM	0.52
4/30/2025	1:30:00 AM	0.53
4/30/2025	1:45:00 AM	0.53
4/30/2025	2:00:00 AM	0.53
4/30/2025	2:15:00 AM	0.53
4/30/2025	2:30:00 AM	0.53
4/30/2025	2:45:00 AM	0.53
4/30/2025	3:00:00 AM	0.53
4/30/2025	3:15:00 AM	0.52
4/30/2025	3:30:00 AM	0.52
4/30/2025	3:45:00 AM	0.52
4/30/2025	4:00:00 AM	0.52
4/30/2025	4:15:00 AM	0.52
4/30/2025	4:30:00 AM	0.52
4/30/2025	4:45:00 AM	0.52
4/30/2025	5:00:00 AM	0.52
4/30/2025	5:15:00 AM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/30/2025	5:30:00 AM	0.51
4/30/2025	5:45:00 AM	0.51
4/30/2025	6:00:00 AM	0.51
4/30/2025	6:15:00 AM	0.51
4/30/2025	6:30:00 AM	0.51
4/30/2025	6:45:00 AM	0.51
4/30/2025	7:00:00 AM	0.5
4/30/2025	7:15:00 AM	0.5
4/30/2025	7:30:00 AM	0.5
4/30/2025	7:45:00 AM	0.5
4/30/2025	8:00:00 AM	0.5
4/30/2025	8:15:00 AM	0.5
4/30/2025	8:30:00 AM	0.49
4/30/2025	8:45:00 AM	0.49
4/30/2025	9:00:00 AM	0.49
4/30/2025	9:15:00 AM	0.49
4/30/2025	9:30:00 AM	0.49
4/30/2025	9:45:00 AM	0.49
4/30/2025	10:00:00 AM	0.49
4/30/2025	10:15:00 AM	0.49
4/30/2025	10:30:00 AM	0.49
4/30/2025	10:45:00 AM	0.48
4/30/2025	11:00:00 AM	0.49
4/30/2025	11:15:00 AM	0.48
4/30/2025	11:30:00 AM	0.48
4/30/2025	11:45:00 AM	0.49
4/30/2025	12:00:00 PM	0.48
4/30/2025	12:15:00 PM	0.48
4/30/2025	12:30:00 PM	0.48
4/30/2025	12:45:00 PM	0.48
4/30/2025	1:00:00 PM	0.48
4/30/2025	1:15:00 PM	0.48
4/30/2025	1:30:00 PM	0.48
4/30/2025	1:45:00 PM	0.48
4/30/2025	2:00:00 PM	0.48
4/30/2025	2:15:00 PM	0.47
4/30/2025	2:30:00 PM	0.47
4/30/2025	2:45:00 PM	0.47
4/30/2025	3:00:00 PM	0.47
4/30/2025	3:15:00 PM	0.47
4/30/2025	3:30:00 PM	0.47
4/30/2025	3:45:00 PM	0.47
4/30/2025	4:00:00 PM	0.47
4/30/2025	4:15:00 PM	0.47
4/30/2025	4:30:00 PM	0.47
4/30/2025	4:45:00 PM	0.47

Blackrock Return Ditch Gage

DATE	TIME	GAGE
4/30/2025	5:00:00 PM	0.47
4/30/2025	5:15:00 PM	0.47
4/30/2025	5:30:00 PM	0.47
4/30/2025	5:45:00 PM	0.47
4/30/2025	6:00:00 PM	0.47
4/30/2025	6:15:00 PM	0.47
4/30/2025	6:30:00 PM	0.47
4/30/2025	6:45:00 PM	0.47
4/30/2025	7:00:00 PM	0.47
4/30/2025	7:15:00 PM	0.47
4/30/2025	7:30:00 PM	0.47
4/30/2025	7:45:00 PM	0.47
4/30/2025	8:00:00 PM	0.47
4/30/2025	8:15:00 PM	0.47
4/30/2025	8:30:00 PM	0.47
4/30/2025	8:45:00 PM	0.47
4/30/2025	9:00:00 PM	0.47
4/30/2025	9:15:00 PM	0.47
4/30/2025	9:30:00 PM	0.47
4/30/2025	9:45:00 PM	0.47
4/30/2025	10:00:00 PM	0.47
4/30/2025	10:15:00 PM	0.47
4/30/2025	10:30:00 PM	0.47
4/30/2025	10:45:00 PM	0.47
4/30/2025	11:00:00 PM	0.47
4/30/2025	11:15:00 PM	0.47
4/30/2025	11:30:00 PM	0.47
4/30/2025	11:45:00 PM	0.48

Billy Lake Return
Station 0213

Date	Flow (cfs)
4/1/2025	1.59
4/2/2025	1.50
4/3/2025	1.42
4/4/2025	1.33
4/5/2025	1.31
4/6/2025	1.49
4/7/2025	1.50
4/8/2025	1.54
4/9/2025	1.56
4/10/2025	1.57
4/11/2025	1.54
4/12/2025	1.57
4/13/2025	1.54
4/14/2025	1.54
4/15/2025	1.40
4/16/2025	1.33
4/17/2025	1.29
4/18/2025	1.12
4/19/2025	1.29
4/20/2025	1.44
4/21/2025	1.44
4/22/2025	1.43
4/23/2025	1.41
4/24/2025	1.48
4/25/2025	1.02
4/26/2025	0.97
4/27/2025	1.60
4/28/2025	1.63
4/29/2025	1.56
4/30/2025	1.45

Billy Lake Return Gage

DATE	TIME	GAGE
4/1/2025	12:00:00 AM	0.36
4/1/2025	12:15:00 AM	0.37
4/1/2025	12:30:00 AM	0.36
4/1/2025	12:45:00 AM	0.36
4/1/2025	1:00:00 AM	0.36
4/1/2025	1:15:00 AM	0.36
4/1/2025	1:30:00 AM	0.36
4/1/2025	1:45:00 AM	0.36
4/1/2025	2:00:00 AM	0.36
4/1/2025	2:15:00 AM	0.37
4/1/2025	2:30:00 AM	0.36
4/1/2025	2:45:00 AM	0.36
4/1/2025	3:00:00 AM	0.36
4/1/2025	3:15:00 AM	0.36
4/1/2025	3:30:00 AM	0.36
4/1/2025	3:45:00 AM	0.36
4/1/2025	4:00:00 AM	0.36
4/1/2025	4:15:00 AM	0.36
4/1/2025	4:30:00 AM	0.36
4/1/2025	4:45:00 AM	0.36
4/1/2025	5:00:00 AM	0.36
4/1/2025	5:15:00 AM	0.36
4/1/2025	5:30:00 AM	0.36
4/1/2025	5:45:00 AM	0.36
4/1/2025	6:00:00 AM	0.36
4/1/2025	6:15:00 AM	0.36
4/1/2025	6:30:00 AM	0.35
4/1/2025	6:45:00 AM	0.35
4/1/2025	7:00:00 AM	0.35
4/1/2025	7:15:00 AM	0.35
4/1/2025	7:30:00 AM	0.35
4/1/2025	7:45:00 AM	0.35
4/1/2025	8:00:00 AM	0.35
4/1/2025	8:15:00 AM	0.35
4/1/2025	8:30:00 AM	0.35
4/1/2025	8:45:00 AM	0.35
4/1/2025	9:00:00 AM	0.35
4/1/2025	9:15:00 AM	0.35
4/1/2025	9:30:00 AM	0.35
4/1/2025	9:45:00 AM	0.35
4/1/2025	10:00:00 AM	0.35
4/1/2025	10:15:00 AM	0.35
4/1/2025	10:30:00 AM	0.35
4/1/2025	10:45:00 AM	0.35
4/1/2025	11:00:00 AM	0.35
4/1/2025	11:15:00 AM	0.35

Billy Lake Return Gage

DATE	TIME	GAGE
4/1/2025	11:30:00 AM	0.35
4/1/2025	11:45:00 AM	0.35
4/1/2025	12:00:00 PM	0.35
4/1/2025	12:15:00 PM	0.35
4/1/2025	12:30:00 PM	0.35
4/1/2025	12:45:00 PM	0.35
4/1/2025	1:00:00 PM	0.35
4/1/2025	1:15:00 PM	0.35
4/1/2025	1:30:00 PM	0.35
4/1/2025	1:45:00 PM	0.35
4/1/2025	2:00:00 PM	0.35
4/1/2025	2:15:00 PM	0.35
4/1/2025	2:30:00 PM	0.35
4/1/2025	2:45:00 PM	0.35
4/1/2025	3:00:00 PM	0.35
4/1/2025	3:15:00 PM	0.35
4/1/2025	3:30:00 PM	0.35
4/1/2025	3:45:00 PM	0.35
4/1/2025	4:00:00 PM	0.35
4/1/2025	4:15:00 PM	0.35
4/1/2025	4:30:00 PM	0.35
4/1/2025	4:45:00 PM	0.35
4/1/2025	5:00:00 PM	0.35
4/1/2025	5:15:00 PM	0.35
4/1/2025	5:30:00 PM	0.35
4/1/2025	5:45:00 PM	0.35
4/1/2025	6:00:00 PM	0.35
4/1/2025	6:15:00 PM	0.35
4/1/2025	6:30:00 PM	0.35
4/1/2025	6:45:00 PM	0.35
4/1/2025	7:00:00 PM	0.35
4/1/2025	7:15:00 PM	0.35
4/1/2025	7:30:00 PM	0.35
4/1/2025	7:45:00 PM	0.35
4/1/2025	8:00:00 PM	0.35
4/1/2025	8:15:00 PM	0.35
4/1/2025	8:30:00 PM	0.35
4/1/2025	8:45:00 PM	0.35
4/1/2025	9:00:00 PM	0.35
4/1/2025	9:15:00 PM	0.35
4/1/2025	9:30:00 PM	0.35
4/1/2025	9:45:00 PM	0.35
4/1/2025	10:00:00 PM	0.35
4/1/2025	10:15:00 PM	0.35
4/1/2025	10:30:00 PM	0.35
4/1/2025	10:45:00 PM	0.35

Billy Lake Return Gage

DATE	TIME	GAGE
4/1/2025	11:00:00 PM	0.35
4/1/2025	11:15:00 PM	0.35
4/1/2025	11:30:00 PM	0.35
4/1/2025	11:45:00 PM	0.35
4/2/2025	12:00:00 AM	0.35
4/2/2025	12:15:00 AM	0.35
4/2/2025	12:30:00 AM	0.35
4/2/2025	12:45:00 AM	0.35
4/2/2025	1:00:00 AM	0.35
4/2/2025	1:15:00 AM	0.35
4/2/2025	1:30:00 AM	0.35
4/2/2025	1:45:00 AM	0.35
4/2/2025	2:00:00 AM	0.35
4/2/2025	2:15:00 AM	0.35
4/2/2025	2:30:00 AM	0.35
4/2/2025	2:45:00 AM	0.35
4/2/2025	3:00:00 AM	0.35
4/2/2025	3:15:00 AM	0.35
4/2/2025	3:30:00 AM	0.35
4/2/2025	3:45:00 AM	0.34
4/2/2025	4:00:00 AM	0.35
4/2/2025	4:15:00 AM	0.34
4/2/2025	4:30:00 AM	0.34
4/2/2025	4:45:00 AM	0.34
4/2/2025	5:00:00 AM	0.34
4/2/2025	5:15:00 AM	0.34
4/2/2025	5:30:00 AM	0.34
4/2/2025	5:45:00 AM	0.34
4/2/2025	6:00:00 AM	0.34
4/2/2025	6:15:00 AM	0.34
4/2/2025	6:30:00 AM	0.34
4/2/2025	6:45:00 AM	0.34
4/2/2025	7:00:00 AM	0.34
4/2/2025	7:15:00 AM	0.34
4/2/2025	7:30:00 AM	0.34
4/2/2025	7:45:00 AM	0.34
4/2/2025	8:00:00 AM	0.34
4/2/2025	8:15:00 AM	0.34
4/2/2025	8:30:00 AM	0.34
4/2/2025	8:45:00 AM	0.34
4/2/2025	9:00:00 AM	0.34
4/2/2025	9:15:00 AM	0.34
4/2/2025	9:30:00 AM	0.34
4/2/2025	9:45:00 AM	0.34
4/2/2025	10:00:00 AM	0.34
4/2/2025	10:15:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
4/2/2025	10:30:00 AM	0.34
4/2/2025	10:45:00 AM	0.34
4/2/2025	11:00:00 AM	0.34
4/2/2025	11:15:00 AM	0.34
4/2/2025	11:30:00 AM	0.34
4/2/2025	11:45:00 AM	0.34
4/2/2025	12:00:00 PM	0.34
4/2/2025	12:15:00 PM	0.34
4/2/2025	12:30:00 PM	0.34
4/2/2025	12:45:00 PM	0.34
4/2/2025	1:00:00 PM	0.34
4/2/2025	1:15:00 PM	0.34
4/2/2025	1:30:00 PM	0.34
4/2/2025	1:45:00 PM	0.34
4/2/2025	2:00:00 PM	0.34
4/2/2025	2:15:00 PM	0.34
4/2/2025	2:30:00 PM	0.34
4/2/2025	2:45:00 PM	0.34
4/2/2025	3:00:00 PM	0.34
4/2/2025	3:15:00 PM	0.34
4/2/2025	3:30:00 PM	0.34
4/2/2025	3:45:00 PM	0.34
4/2/2025	4:00:00 PM	0.34
4/2/2025	4:15:00 PM	0.34
4/2/2025	4:30:00 PM	0.34
4/2/2025	4:45:00 PM	0.34
4/2/2025	5:00:00 PM	0.34
4/2/2025	5:15:00 PM	0.34
4/2/2025	5:30:00 PM	0.34
4/2/2025	5:45:00 PM	0.34
4/2/2025	6:00:00 PM	0.34
4/2/2025	6:15:00 PM	0.34
4/2/2025	6:30:00 PM	0.33
4/2/2025	6:45:00 PM	0.33
4/2/2025	7:00:00 PM	0.34
4/2/2025	7:15:00 PM	0.33
4/2/2025	7:30:00 PM	0.33
4/2/2025	7:45:00 PM	0.33
4/2/2025	8:00:00 PM	0.33
4/2/2025	8:15:00 PM	0.33
4/2/2025	8:30:00 PM	0.33
4/2/2025	8:45:00 PM	0.33
4/2/2025	9:00:00 PM	0.33
4/2/2025	9:15:00 PM	0.33
4/2/2025	9:30:00 PM	0.33
4/2/2025	9:45:00 PM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
4/2/2025	10:00:00 PM	0.33
4/2/2025	10:15:00 PM	0.33
4/2/2025	10:30:00 PM	0.33
4/2/2025	10:45:00 PM	0.33
4/2/2025	11:00:00 PM	0.33
4/2/2025	11:15:00 PM	0.33
4/2/2025	11:30:00 PM	0.33
4/2/2025	11:45:00 PM	0.33
4/3/2025	12:00:00 AM	0.33
4/3/2025	12:15:00 AM	0.33
4/3/2025	12:30:00 AM	0.33
4/3/2025	12:45:00 AM	0.33
4/3/2025	1:00:00 AM	0.33
4/3/2025	1:15:00 AM	0.33
4/3/2025	1:30:00 AM	0.33
4/3/2025	1:45:00 AM	0.32
4/3/2025	2:00:00 AM	0.32
4/3/2025	2:15:00 AM	0.33
4/3/2025	2:30:00 AM	0.33
4/3/2025	2:45:00 AM	0.32
4/3/2025	3:00:00 AM	0.32
4/3/2025	3:15:00 AM	0.32
4/3/2025	3:30:00 AM	0.32
4/3/2025	3:45:00 AM	0.32
4/3/2025	4:00:00 AM	0.32
4/3/2025	4:15:00 AM	0.32
4/3/2025	4:30:00 AM	0.32
4/3/2025	4:45:00 AM	0.32
4/3/2025	5:00:00 AM	0.32
4/3/2025	5:15:00 AM	0.32
4/3/2025	5:30:00 AM	0.32
4/3/2025	5:45:00 AM	0.32
4/3/2025	6:00:00 AM	0.32
4/3/2025	6:15:00 AM	0.32
4/3/2025	6:30:00 AM	0.32
4/3/2025	6:45:00 AM	0.32
4/3/2025	7:00:00 AM	0.32
4/3/2025	7:15:00 AM	0.32
4/3/2025	7:30:00 AM	0.32
4/3/2025	7:45:00 AM	0.32
4/3/2025	8:00:00 AM	0.32
4/3/2025	8:15:00 AM	0.32
4/3/2025	8:30:00 AM	0.32
4/3/2025	8:45:00 AM	0.32
4/3/2025	9:00:00 AM	0.32
4/3/2025	9:15:00 AM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
4/3/2025	9:30:00 AM	0.32
4/3/2025	9:45:00 AM	0.33
4/3/2025	10:00:00 AM	0.33
4/3/2025	10:15:00 AM	0.33
4/3/2025	10:30:00 AM	0.33
4/3/2025	10:45:00 AM	0.33
4/3/2025	11:00:00 AM	0.33
4/3/2025	11:15:00 AM	0.33
4/3/2025	11:30:00 AM	0.33
4/3/2025	11:45:00 AM	0.33
4/3/2025	12:00:00 PM	0.33
4/3/2025	12:15:00 PM	0.33
4/3/2025	12:30:00 PM	0.33
4/3/2025	12:45:00 PM	0.33
4/3/2025	1:00:00 PM	0.33
4/3/2025	1:15:00 PM	0.34
4/3/2025	1:30:00 PM	0.33
4/3/2025	1:45:00 PM	0.34
4/3/2025	2:00:00 PM	0.33
4/3/2025	2:15:00 PM	0.33
4/3/2025	2:30:00 PM	0.33
4/3/2025	2:45:00 PM	0.33
4/3/2025	3:00:00 PM	0.33
4/3/2025	3:15:00 PM	0.33
4/3/2025	3:30:00 PM	0.33
4/3/2025	3:45:00 PM	0.33
4/3/2025	4:00:00 PM	0.33
4/3/2025	4:15:00 PM	0.33
4/3/2025	4:30:00 PM	0.33
4/3/2025	4:45:00 PM	0.33
4/3/2025	5:00:00 PM	0.33
4/3/2025	5:15:00 PM	0.33
4/3/2025	5:30:00 PM	0.33
4/3/2025	5:45:00 PM	0.33
4/3/2025	6:00:00 PM	0.33
4/3/2025	6:15:00 PM	0.33
4/3/2025	6:30:00 PM	0.33
4/3/2025	6:45:00 PM	0.33
4/3/2025	7:00:00 PM	0.33
4/3/2025	7:15:00 PM	0.33
4/3/2025	7:30:00 PM	0.33
4/3/2025	7:45:00 PM	0.33
4/3/2025	8:00:00 PM	0.33
4/3/2025	8:15:00 PM	0.33
4/3/2025	8:30:00 PM	0.33
4/3/2025	8:45:00 PM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
4/3/2025	9:00:00 PM	0.33
4/3/2025	9:15:00 PM	0.33
4/3/2025	9:30:00 PM	0.33
4/3/2025	9:45:00 PM	0.33
4/3/2025	10:00:00 PM	0.33
4/3/2025	10:15:00 PM	0.33
4/3/2025	10:30:00 PM	0.33
4/3/2025	10:45:00 PM	0.33
4/3/2025	11:00:00 PM	0.33
4/3/2025	11:15:00 PM	0.33
4/3/2025	11:30:00 PM	0.33
4/3/2025	11:45:00 PM	0.33
4/4/2025	12:00:00 AM	0.33
4/4/2025	12:15:00 AM	0.32
4/4/2025	12:30:00 AM	0.32
4/4/2025	12:45:00 AM	0.32
4/4/2025	1:00:00 AM	0.32
4/4/2025	1:15:00 AM	0.32
4/4/2025	1:30:00 AM	0.32
4/4/2025	1:45:00 AM	0.32
4/4/2025	2:00:00 AM	0.32
4/4/2025	2:15:00 AM	0.32
4/4/2025	2:30:00 AM	0.32
4/4/2025	2:45:00 AM	0.32
4/4/2025	3:00:00 AM	0.32
4/4/2025	3:15:00 AM	0.32
4/4/2025	3:30:00 AM	0.32
4/4/2025	3:45:00 AM	0.32
4/4/2025	4:00:00 AM	0.32
4/4/2025	4:15:00 AM	0.32
4/4/2025	4:30:00 AM	0.32
4/4/2025	4:45:00 AM	0.32
4/4/2025	5:00:00 AM	0.32
4/4/2025	5:15:00 AM	0.32
4/4/2025	5:30:00 AM	0.32
4/4/2025	5:45:00 AM	0.32
4/4/2025	6:00:00 AM	0.32
4/4/2025	6:15:00 AM	0.32
4/4/2025	6:30:00 AM	0.32
4/4/2025	6:45:00 AM	0.32
4/4/2025	7:00:00 AM	0.32
4/4/2025	7:15:00 AM	0.32
4/4/2025	7:30:00 AM	0.32
4/4/2025	7:45:00 AM	0.32
4/4/2025	8:00:00 AM	0.32
4/4/2025	8:15:00 AM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
4/4/2025	8:30:00 AM	0.32
4/4/2025	8:45:00 AM	0.32
4/4/2025	9:00:00 AM	0.32
4/4/2025	9:15:00 AM	0.32
4/4/2025	9:30:00 AM	0.32
4/4/2025	9:45:00 AM	0.32
4/4/2025	10:00:00 AM	0.32
4/4/2025	10:15:00 AM	0.32
4/4/2025	10:30:00 AM	0.32
4/4/2025	10:45:00 AM	0.32
4/4/2025	11:00:00 AM	0.31
4/4/2025	11:15:00 AM	0.31
4/4/2025	11:30:00 AM	0.31
4/4/2025	11:45:00 AM	0.31
4/4/2025	12:00:00 PM	0.31
4/4/2025	12:15:00 PM	0.31
4/4/2025	12:30:00 PM	0.31
4/4/2025	12:45:00 PM	0.31
4/4/2025	1:00:00 PM	0.31
4/4/2025	1:15:00 PM	0.31
4/4/2025	1:30:00 PM	0.31
4/4/2025	1:45:00 PM	0.31
4/4/2025	2:00:00 PM	0.31
4/4/2025	2:15:00 PM	0.31
4/4/2025	2:30:00 PM	0.31
4/4/2025	2:45:00 PM	0.31
4/4/2025	3:00:00 PM	0.31
4/4/2025	3:15:00 PM	0.31
4/4/2025	3:30:00 PM	0.31
4/4/2025	3:45:00 PM	0.31
4/4/2025	4:00:00 PM	0.31
4/4/2025	4:15:00 PM	0.31
4/4/2025	4:30:00 PM	0.31
4/4/2025	4:45:00 PM	0.31
4/4/2025	5:00:00 PM	0.31
4/4/2025	5:15:00 PM	0.31
4/4/2025	5:30:00 PM	0.31
4/4/2025	5:45:00 PM	0.31
4/4/2025	6:00:00 PM	0.31
4/4/2025	6:15:00 PM	0.31
4/4/2025	6:30:00 PM	0.31
4/4/2025	6:45:00 PM	0.31
4/4/2025	7:00:00 PM	0.31
4/4/2025	7:15:00 PM	0.31
4/4/2025	7:30:00 PM	0.31
4/4/2025	7:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
4/4/2025	8:00:00 PM	0.31
4/4/2025	8:15:00 PM	0.31
4/4/2025	8:30:00 PM	0.31
4/4/2025	8:45:00 PM	0.31
4/4/2025	9:00:00 PM	0.31
4/4/2025	9:15:00 PM	0.3
4/4/2025	9:30:00 PM	0.3
4/4/2025	9:45:00 PM	0.31
4/4/2025	10:00:00 PM	0.31
4/4/2025	10:15:00 PM	0.31
4/4/2025	10:30:00 PM	0.3
4/4/2025	10:45:00 PM	0.3
4/4/2025	11:00:00 PM	0.3
4/4/2025	11:15:00 PM	0.3
4/4/2025	11:30:00 PM	0.3
4/4/2025	11:45:00 PM	0.3
4/5/2025	12:00:00 AM	0.3
4/5/2025	12:15:00 AM	0.3
4/5/2025	12:30:00 AM	0.3
4/5/2025	12:45:00 AM	0.3
4/5/2025	1:00:00 AM	0.3
4/5/2025	1:15:00 AM	0.3
4/5/2025	1:30:00 AM	0.3
4/5/2025	1:45:00 AM	0.3
4/5/2025	2:00:00 AM	0.3
4/5/2025	2:15:00 AM	0.3
4/5/2025	2:30:00 AM	0.3
4/5/2025	2:45:00 AM	0.3
4/5/2025	3:00:00 AM	0.3
4/5/2025	3:15:00 AM	0.3
4/5/2025	3:30:00 AM	0.3
4/5/2025	3:45:00 AM	0.3
4/5/2025	4:00:00 AM	0.3
4/5/2025	4:15:00 AM	0.3
4/5/2025	4:30:00 AM	0.3
4/5/2025	4:45:00 AM	0.3
4/5/2025	5:00:00 AM	0.3
4/5/2025	5:15:00 AM	0.3
4/5/2025	5:30:00 AM	0.3
4/5/2025	5:45:00 AM	0.3
4/5/2025	6:00:00 AM	0.3
4/5/2025	6:15:00 AM	0.3
4/5/2025	6:30:00 AM	0.3
4/5/2025	6:45:00 AM	0.3
4/5/2025	7:00:00 AM	0.3
4/5/2025	7:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
4/5/2025	7:30:00 AM	0.3
4/5/2025	7:45:00 AM	0.3
4/5/2025	8:00:00 AM	0.3
4/5/2025	8:15:00 AM	0.3
4/5/2025	8:30:00 AM	0.3
4/5/2025	8:45:00 AM	0.3
4/5/2025	9:00:00 AM	0.3
4/5/2025	9:15:00 AM	0.3
4/5/2025	9:30:00 AM	0.3
4/5/2025	9:45:00 AM	0.3
4/5/2025	10:00:00 AM	0.3
4/5/2025	10:15:00 AM	0.3
4/5/2025	10:30:00 AM	0.3
4/5/2025	10:45:00 AM	0.3
4/5/2025	11:00:00 AM	0.3
4/5/2025	11:15:00 AM	0.3
4/5/2025	11:30:00 AM	0.3
4/5/2025	11:45:00 AM	0.3
4/5/2025	12:00:00 PM	0.3
4/5/2025	12:15:00 PM	0.3
4/5/2025	12:30:00 PM	0.3
4/5/2025	12:45:00 PM	0.3
4/5/2025	1:00:00 PM	0.3
4/5/2025	1:15:00 PM	0.3
4/5/2025	1:30:00 PM	0.31
4/5/2025	1:45:00 PM	0.31
4/5/2025	2:00:00 PM	0.31
4/5/2025	2:15:00 PM	0.31
4/5/2025	2:30:00 PM	0.31
4/5/2025	2:45:00 PM	0.31
4/5/2025	3:00:00 PM	0.31
4/5/2025	3:15:00 PM	0.32
4/5/2025	3:30:00 PM	0.32
4/5/2025	3:45:00 PM	0.32
4/5/2025	4:00:00 PM	0.32
4/5/2025	4:15:00 PM	0.32
4/5/2025	4:30:00 PM	0.32
4/5/2025	4:45:00 PM	0.32
4/5/2025	5:00:00 PM	0.32
4/5/2025	5:15:00 PM	0.32
4/5/2025	5:30:00 PM	0.32
4/5/2025	5:45:00 PM	0.32
4/5/2025	6:00:00 PM	0.32
4/5/2025	6:15:00 PM	0.32
4/5/2025	6:30:00 PM	0.33
4/5/2025	6:45:00 PM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
4/5/2025	7:00:00 PM	0.33
4/5/2025	7:15:00 PM	0.33
4/5/2025	7:30:00 PM	0.33
4/5/2025	7:45:00 PM	0.33
4/5/2025	8:00:00 PM	0.33
4/5/2025	8:15:00 PM	0.33
4/5/2025	8:30:00 PM	0.33
4/5/2025	8:45:00 PM	0.33
4/5/2025	9:00:00 PM	0.33
4/5/2025	9:15:00 PM	0.33
4/5/2025	9:30:00 PM	0.33
4/5/2025	9:45:00 PM	0.33
4/5/2025	10:00:00 PM	0.33
4/5/2025	10:15:00 PM	0.33
4/5/2025	10:30:00 PM	0.33
4/5/2025	10:45:00 PM	0.33
4/5/2025	11:00:00 PM	0.33
4/5/2025	11:15:00 PM	0.33
4/5/2025	11:30:00 PM	0.33
4/5/2025	11:45:00 PM	0.33
4/6/2025	12:00:00 AM	0.33
4/6/2025	12:15:00 AM	0.33
4/6/2025	12:30:00 AM	0.33
4/6/2025	12:45:00 AM	0.33
4/6/2025	1:00:00 AM	0.33
4/6/2025	1:15:00 AM	0.33
4/6/2025	1:30:00 AM	0.33
4/6/2025	1:45:00 AM	0.33
4/6/2025	2:00:00 AM	0.33
4/6/2025	2:15:00 AM	0.33
4/6/2025	2:30:00 AM	0.33
4/6/2025	2:45:00 AM	0.34
4/6/2025	3:00:00 AM	0.34
4/6/2025	3:15:00 AM	0.33
4/6/2025	3:30:00 AM	0.33
4/6/2025	3:45:00 AM	0.34
4/6/2025	4:00:00 AM	0.34
4/6/2025	4:15:00 AM	0.34
4/6/2025	4:30:00 AM	0.34
4/6/2025	4:45:00 AM	0.34
4/6/2025	5:00:00 AM	0.34
4/6/2025	5:15:00 AM	0.34
4/6/2025	5:30:00 AM	0.34
4/6/2025	5:45:00 AM	0.34
4/6/2025	6:00:00 AM	0.34
4/6/2025	6:15:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
4/6/2025	6:30:00 AM	0.34
4/6/2025	6:45:00 AM	0.34
4/6/2025	7:00:00 AM	0.34
4/6/2025	7:15:00 AM	0.34
4/6/2025	7:30:00 AM	0.34
4/6/2025	7:45:00 AM	0.34
4/6/2025	8:00:00 AM	0.34
4/6/2025	8:15:00 AM	0.34
4/6/2025	8:30:00 AM	0.34
4/6/2025	8:45:00 AM	0.34
4/6/2025	9:00:00 AM	0.34
4/6/2025	9:15:00 AM	0.34
4/6/2025	9:30:00 AM	0.34
4/6/2025	9:45:00 AM	0.34
4/6/2025	10:00:00 AM	0.34
4/6/2025	10:15:00 AM	0.34
4/6/2025	10:30:00 AM	0.34
4/6/2025	10:45:00 AM	0.34
4/6/2025	11:00:00 AM	0.34
4/6/2025	11:15:00 AM	0.34
4/6/2025	11:30:00 AM	0.34
4/6/2025	11:45:00 AM	0.34
4/6/2025	12:00:00 PM	0.34
4/6/2025	12:15:00 PM	0.34
4/6/2025	12:30:00 PM	0.34
4/6/2025	12:45:00 PM	0.34
4/6/2025	1:00:00 PM	0.34
4/6/2025	1:15:00 PM	0.34
4/6/2025	1:30:00 PM	0.34
4/6/2025	1:45:00 PM	0.34
4/6/2025	2:00:00 PM	0.34
4/6/2025	2:15:00 PM	0.34
4/6/2025	2:30:00 PM	0.34
4/6/2025	2:45:00 PM	0.34
4/6/2025	3:00:00 PM	0.34
4/6/2025	3:15:00 PM	0.34
4/6/2025	3:30:00 PM	0.34
4/6/2025	3:45:00 PM	0.34
4/6/2025	4:00:00 PM	0.34
4/6/2025	4:15:00 PM	0.34
4/6/2025	4:30:00 PM	0.34
4/6/2025	4:45:00 PM	0.34
4/6/2025	5:00:00 PM	0.34
4/6/2025	5:15:00 PM	0.34
4/6/2025	5:30:00 PM	0.34
4/6/2025	5:45:00 PM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
4/6/2025	6:00:00 PM	0.34
4/6/2025	6:15:00 PM	0.34
4/6/2025	6:30:00 PM	0.34
4/6/2025	6:45:00 PM	0.34
4/6/2025	7:00:00 PM	0.34
4/6/2025	7:15:00 PM	0.34
4/6/2025	7:30:00 PM	0.34
4/6/2025	7:45:00 PM	0.34
4/6/2025	8:00:00 PM	0.34
4/6/2025	8:15:00 PM	0.34
4/6/2025	8:30:00 PM	0.34
4/6/2025	8:45:00 PM	0.34
4/6/2025	9:00:00 PM	0.34
4/6/2025	9:15:00 PM	0.34
4/6/2025	9:30:00 PM	0.34
4/6/2025	9:45:00 PM	0.34
4/6/2025	10:00:00 PM	0.34
4/6/2025	10:15:00 PM	0.34
4/6/2025	10:30:00 PM	0.34
4/6/2025	10:45:00 PM	0.34
4/6/2025	11:00:00 PM	0.34
4/6/2025	11:15:00 PM	0.34
4/6/2025	11:30:00 PM	0.34
4/6/2025	11:45:00 PM	0.34
4/7/2025	12:00:00 AM	0.34
4/7/2025	12:15:00 AM	0.34
4/7/2025	12:30:00 AM	0.34
4/7/2025	12:45:00 AM	0.34
4/7/2025	1:00:00 AM	0.34
4/7/2025	1:15:00 AM	0.34
4/7/2025	1:30:00 AM	0.34
4/7/2025	1:45:00 AM	0.34
4/7/2025	2:00:00 AM	0.34
4/7/2025	2:15:00 AM	0.34
4/7/2025	2:30:00 AM	0.34
4/7/2025	2:45:00 AM	0.34
4/7/2025	3:00:00 AM	0.34
4/7/2025	3:15:00 AM	0.34
4/7/2025	3:30:00 AM	0.34
4/7/2025	3:45:00 AM	0.34
4/7/2025	4:00:00 AM	0.34
4/7/2025	4:15:00 AM	0.34
4/7/2025	4:30:00 AM	0.34
4/7/2025	4:45:00 AM	0.34
4/7/2025	5:00:00 AM	0.34
4/7/2025	5:15:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
4/7/2025	5:30:00 AM	0.34
4/7/2025	5:45:00 AM	0.34
4/7/2025	6:00:00 AM	0.34
4/7/2025	6:15:00 AM	0.34
4/7/2025	6:30:00 AM	0.34
4/7/2025	6:45:00 AM	0.34
4/7/2025	7:00:00 AM	0.34
4/7/2025	7:15:00 AM	0.34
4/7/2025	7:30:00 AM	0.34
4/7/2025	7:45:00 AM	0.34
4/7/2025	8:00:00 AM	0.34
4/7/2025	8:15:00 AM	0.34
4/7/2025	8:30:00 AM	0.34
4/7/2025	8:45:00 AM	0.34
4/7/2025	9:00:00 AM	0.34
4/7/2025	9:15:00 AM	0.34
4/7/2025	9:30:00 AM	0.34
4/7/2025	9:45:00 AM	0.34
4/7/2025	10:00:00 AM	0.34
4/7/2025	10:15:00 AM	0.34
4/7/2025	10:30:00 AM	0.34
4/7/2025	10:45:00 AM	0.34
4/7/2025	11:00:00 AM	0.34
4/7/2025	11:15:00 AM	0.34
4/7/2025	11:30:00 AM	0.34
4/7/2025	11:45:00 AM	0.34
4/7/2025	12:00:00 PM	0.34
4/7/2025	12:15:00 PM	0.34
4/7/2025	12:30:00 PM	0.34
4/7/2025	12:45:00 PM	0.34
4/7/2025	1:00:00 PM	0.34
4/7/2025	1:15:00 PM	0.34
4/7/2025	1:30:00 PM	0.34
4/7/2025	1:45:00 PM	0.34
4/7/2025	2:00:00 PM	0.34
4/7/2025	2:15:00 PM	0.34
4/7/2025	2:30:00 PM	0.34
4/7/2025	2:45:00 PM	0.34
4/7/2025	3:00:00 PM	0.34
4/7/2025	3:15:00 PM	0.34
4/7/2025	3:30:00 PM	0.34
4/7/2025	3:45:00 PM	0.34
4/7/2025	4:00:00 PM	0.34
4/7/2025	4:15:00 PM	0.34
4/7/2025	4:30:00 PM	0.34
4/7/2025	4:45:00 PM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
4/7/2025	5:00:00 PM	0.34
4/7/2025	5:15:00 PM	0.34
4/7/2025	5:30:00 PM	0.34
4/7/2025	5:45:00 PM	0.34
4/7/2025	6:00:00 PM	0.34
4/7/2025	6:15:00 PM	0.34
4/7/2025	6:30:00 PM	0.34
4/7/2025	6:45:00 PM	0.34
4/7/2025	7:00:00 PM	0.34
4/7/2025	7:15:00 PM	0.34
4/7/2025	7:30:00 PM	0.34
4/7/2025	7:45:00 PM	0.34
4/7/2025	8:00:00 PM	0.34
4/7/2025	8:15:00 PM	0.34
4/7/2025	8:30:00 PM	0.34
4/7/2025	8:45:00 PM	0.34
4/7/2025	9:00:00 PM	0.34
4/7/2025	9:15:00 PM	0.34
4/7/2025	9:30:00 PM	0.34
4/7/2025	9:45:00 PM	0.34
4/7/2025	10:00:00 PM	0.34
4/7/2025	10:15:00 PM	0.34
4/7/2025	10:30:00 PM	0.34
4/7/2025	10:45:00 PM	0.34
4/7/2025	11:00:00 PM	0.34
4/7/2025	11:15:00 PM	0.34
4/7/2025	11:30:00 PM	0.34
4/7/2025	11:45:00 PM	0.34
4/8/2025	12:00:00 AM	0.34
4/8/2025	12:15:00 AM	0.34
4/8/2025	12:30:00 AM	0.34
4/8/2025	12:45:00 AM	0.34
4/8/2025	1:00:00 AM	0.34
4/8/2025	1:15:00 AM	0.34
4/8/2025	1:30:00 AM	0.34
4/8/2025	1:45:00 AM	0.34
4/8/2025	2:00:00 AM	0.34
4/8/2025	2:15:00 AM	0.34
4/8/2025	2:30:00 AM	0.34
4/8/2025	2:45:00 AM	0.34
4/8/2025	3:00:00 AM	0.34
4/8/2025	3:15:00 AM	0.34
4/8/2025	3:30:00 AM	0.34
4/8/2025	3:45:00 AM	0.34
4/8/2025	4:00:00 AM	0.34
4/8/2025	4:15:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
4/8/2025	4:30:00 AM	0.34
4/8/2025	4:45:00 AM	0.34
4/8/2025	5:00:00 AM	0.34
4/8/2025	5:15:00 AM	0.34
4/8/2025	5:30:00 AM	0.34
4/8/2025	5:45:00 AM	0.34
4/8/2025	6:00:00 AM	0.34
4/8/2025	6:15:00 AM	0.34
4/8/2025	6:30:00 AM	0.34
4/8/2025	6:45:00 AM	0.34
4/8/2025	7:00:00 AM	0.35
4/8/2025	7:15:00 AM	0.35
4/8/2025	7:30:00 AM	0.35
4/8/2025	7:45:00 AM	0.35
4/8/2025	8:00:00 AM	0.35
4/8/2025	8:15:00 AM	0.35
4/8/2025	8:30:00 AM	0.34
4/8/2025	8:45:00 AM	0.35
4/8/2025	9:00:00 AM	0.35
4/8/2025	9:15:00 AM	0.35
4/8/2025	9:30:00 AM	0.35
4/8/2025	9:45:00 AM	0.35
4/8/2025	10:00:00 AM	0.35
4/8/2025	10:15:00 AM	0.35
4/8/2025	10:30:00 AM	0.35
4/8/2025	10:45:00 AM	0.35
4/8/2025	11:00:00 AM	0.35
4/8/2025	11:15:00 AM	0.35
4/8/2025	11:30:00 AM	0.35
4/8/2025	11:45:00 AM	0.35
4/8/2025	12:00:00 PM	0.35
4/8/2025	12:15:00 PM	0.35
4/8/2025	12:30:00 PM	0.35
4/8/2025	12:45:00 PM	0.35
4/8/2025	1:00:00 PM	0.35
4/8/2025	1:15:00 PM	0.35
4/8/2025	1:30:00 PM	0.35
4/8/2025	1:45:00 PM	0.35
4/8/2025	2:00:00 PM	0.35
4/8/2025	2:15:00 PM	0.35
4/8/2025	2:30:00 PM	0.35
4/8/2025	2:45:00 PM	0.35
4/8/2025	3:00:00 PM	0.35
4/8/2025	3:15:00 PM	0.35
4/8/2025	3:30:00 PM	0.35
4/8/2025	3:45:00 PM	0.35

Billy Lake Return Gage

DATE	TIME	GAGE
4/8/2025	4:00:00 PM	0.35
4/8/2025	4:15:00 PM	0.35
4/8/2025	4:30:00 PM	0.35
4/8/2025	4:45:00 PM	0.35
4/8/2025	5:00:00 PM	0.35
4/8/2025	5:15:00 PM	0.34
4/8/2025	5:30:00 PM	0.35
4/8/2025	5:45:00 PM	0.35
4/8/2025	6:00:00 PM	0.34
4/8/2025	6:15:00 PM	0.35
4/8/2025	6:30:00 PM	0.34
4/8/2025	6:45:00 PM	0.34
4/8/2025	7:00:00 PM	0.34
4/8/2025	7:15:00 PM	0.34
4/8/2025	7:30:00 PM	0.35
4/8/2025	7:45:00 PM	0.34
4/8/2025	8:00:00 PM	0.34
4/8/2025	8:15:00 PM	0.35
4/8/2025	8:30:00 PM	0.35
4/8/2025	8:45:00 PM	0.34
4/8/2025	9:00:00 PM	0.35
4/8/2025	9:15:00 PM	0.34
4/8/2025	9:30:00 PM	0.34
4/8/2025	9:45:00 PM	0.35
4/8/2025	10:00:00 PM	0.34
4/8/2025	10:15:00 PM	0.34
4/8/2025	10:30:00 PM	0.34
4/8/2025	10:45:00 PM	0.35
4/8/2025	11:00:00 PM	0.34
4/8/2025	11:15:00 PM	0.34
4/8/2025	11:30:00 PM	0.34
4/8/2025	11:45:00 PM	0.34
4/9/2025	12:00:00 AM	0.34
4/9/2025	12:15:00 AM	0.34
4/9/2025	12:30:00 AM	0.35
4/9/2025	12:45:00 AM	0.35
4/9/2025	1:00:00 AM	0.35
4/9/2025	1:15:00 AM	0.34
4/9/2025	1:30:00 AM	0.35
4/9/2025	1:45:00 AM	0.35
4/9/2025	2:00:00 AM	0.34
4/9/2025	2:15:00 AM	0.35
4/9/2025	2:30:00 AM	0.34
4/9/2025	2:45:00 AM	0.35
4/9/2025	3:00:00 AM	0.35
4/9/2025	3:15:00 AM	0.35

Billy Lake Return Gage

DATE	TIME	GAGE
4/9/2025	3:30:00 AM	0.35
4/9/2025	3:45:00 AM	0.35
4/9/2025	4:00:00 AM	0.34
4/9/2025	4:15:00 AM	0.35
4/9/2025	4:30:00 AM	0.34
4/9/2025	4:45:00 AM	0.34
4/9/2025	5:00:00 AM	0.34
4/9/2025	5:15:00 AM	0.34
4/9/2025	5:30:00 AM	0.35
4/9/2025	5:45:00 AM	0.35
4/9/2025	6:00:00 AM	0.34
4/9/2025	6:15:00 AM	0.34
4/9/2025	6:30:00 AM	0.35
4/9/2025	6:45:00 AM	0.35
4/9/2025	7:00:00 AM	0.34
4/9/2025	7:15:00 AM	0.34
4/9/2025	7:30:00 AM	0.35
4/9/2025	7:45:00 AM	0.35
4/9/2025	8:00:00 AM	0.35
4/9/2025	8:15:00 AM	0.35
4/9/2025	8:30:00 AM	0.35
4/9/2025	8:45:00 AM	0.35
4/9/2025	9:00:00 AM	0.35
4/9/2025	9:15:00 AM	0.35
4/9/2025	9:30:00 AM	0.35
4/9/2025	9:45:00 AM	0.35
4/9/2025	10:00:00 AM	0.35
4/9/2025	10:15:00 AM	0.35
4/9/2025	10:30:00 AM	0.35
4/9/2025	10:45:00 AM	0.35
4/9/2025	11:00:00 AM	0.35
4/9/2025	11:15:00 AM	0.35
4/9/2025	11:30:00 AM	0.35
4/9/2025	11:45:00 AM	0.35
4/9/2025	12:00:00 PM	0.35
4/9/2025	12:15:00 PM	0.35
4/9/2025	12:30:00 PM	0.35
4/9/2025	12:45:00 PM	0.35
4/9/2025	1:00:00 PM	0.35
4/9/2025	1:15:00 PM	0.35
4/9/2025	1:30:00 PM	0.35
4/9/2025	1:45:00 PM	0.35
4/9/2025	2:00:00 PM	0.35
4/9/2025	2:15:00 PM	0.35
4/9/2025	2:30:00 PM	0.35
4/9/2025	2:45:00 PM	0.35

Billy Lake Return Gage

DATE	TIME	GAGE
4/9/2025	3:00:00 PM	0.35
4/9/2025	3:15:00 PM	0.35
4/9/2025	3:30:00 PM	0.35
4/9/2025	3:45:00 PM	0.35
4/9/2025	4:00:00 PM	0.35
4/9/2025	4:15:00 PM	0.35
4/9/2025	4:30:00 PM	0.35
4/9/2025	4:45:00 PM	0.35
4/9/2025	5:00:00 PM	0.35
4/9/2025	5:15:00 PM	0.35
4/9/2025	5:30:00 PM	0.34
4/9/2025	5:45:00 PM	0.35
4/9/2025	6:00:00 PM	0.35
4/9/2025	6:15:00 PM	0.35
4/9/2025	6:30:00 PM	0.35
4/9/2025	6:45:00 PM	0.35
4/9/2025	7:00:00 PM	0.35
4/9/2025	7:15:00 PM	0.35
4/9/2025	7:30:00 PM	0.35
4/9/2025	7:45:00 PM	0.35
4/9/2025	8:00:00 PM	0.35
4/9/2025	8:15:00 PM	0.35
4/9/2025	8:30:00 PM	0.35
4/9/2025	8:45:00 PM	0.34
4/9/2025	9:00:00 PM	0.34
4/9/2025	9:15:00 PM	0.35
4/9/2025	9:30:00 PM	0.34
4/9/2025	9:45:00 PM	0.34
4/9/2025	10:00:00 PM	0.34
4/9/2025	10:15:00 PM	0.35
4/9/2025	10:30:00 PM	0.34
4/9/2025	10:45:00 PM	0.35
4/9/2025	11:00:00 PM	0.35
4/9/2025	11:15:00 PM	0.35
4/9/2025	11:30:00 PM	0.35
4/9/2025	11:45:00 PM	0.35
4/10/2025	12:00:00 AM	0.35
4/10/2025	12:15:00 AM	0.35
4/10/2025	12:30:00 AM	0.35
4/10/2025	12:45:00 AM	0.35
4/10/2025	1:00:00 AM	0.35
4/10/2025	1:15:00 AM	0.35
4/10/2025	1:30:00 AM	0.35
4/10/2025	1:45:00 AM	0.35
4/10/2025	2:00:00 AM	0.35
4/10/2025	2:15:00 AM	0.35

Billy Lake Return Gage

DATE	TIME	GAGE
4/10/2025	2:30:00 AM	0.34
4/10/2025	2:45:00 AM	0.35
4/10/2025	3:00:00 AM	0.35
4/10/2025	3:15:00 AM	0.35
4/10/2025	3:30:00 AM	0.35
4/10/2025	3:45:00 AM	0.35
4/10/2025	4:00:00 AM	0.35
4/10/2025	4:15:00 AM	0.35
4/10/2025	4:30:00 AM	0.35
4/10/2025	4:45:00 AM	0.35
4/10/2025	5:00:00 AM	0.35
4/10/2025	5:15:00 AM	0.35
4/10/2025	5:30:00 AM	0.35
4/10/2025	5:45:00 AM	0.35
4/10/2025	6:00:00 AM	0.35
4/10/2025	6:15:00 AM	0.35
4/10/2025	6:30:00 AM	0.35
4/10/2025	6:45:00 AM	0.35
4/10/2025	7:00:00 AM	0.35
4/10/2025	7:15:00 AM	0.35
4/10/2025	7:30:00 AM	0.35
4/10/2025	7:45:00 AM	0.35
4/10/2025	8:00:00 AM	0.35
4/10/2025	8:15:00 AM	0.35
4/10/2025	8:30:00 AM	0.35
4/10/2025	8:45:00 AM	0.35
4/10/2025	9:00:00 AM	0.35
4/10/2025	9:15:00 AM	0.35
4/10/2025	9:30:00 AM	0.35
4/10/2025	9:45:00 AM	0.35
4/10/2025	10:00:00 AM	0.35
4/10/2025	10:15:00 AM	0.35
4/10/2025	10:30:00 AM	0.35
4/10/2025	10:45:00 AM	0.35
4/10/2025	11:00:00 AM	0.35
4/10/2025	11:15:00 AM	0.35
4/10/2025	11:30:00 AM	0.35
4/10/2025	11:45:00 AM	0.35
4/10/2025	12:00:00 PM	0.35
4/10/2025	12:15:00 PM	0.35
4/10/2025	12:30:00 PM	0.35
4/10/2025	12:45:00 PM	0.35
4/10/2025	1:00:00 PM	0.35
4/10/2025	1:15:00 PM	0.35
4/10/2025	1:30:00 PM	0.35
4/10/2025	1:45:00 PM	0.35

Billy Lake Return Gage

DATE	TIME	GAGE
4/10/2025	2:00:00 PM	0.35
4/10/2025	2:15:00 PM	0.35
4/10/2025	2:30:00 PM	0.35
4/10/2025	2:45:00 PM	0.35
4/10/2025	3:00:00 PM	0.35
4/10/2025	3:15:00 PM	0.35
4/10/2025	3:30:00 PM	0.35
4/10/2025	3:45:00 PM	0.34
4/10/2025	4:00:00 PM	0.35
4/10/2025	4:15:00 PM	0.35
4/10/2025	4:30:00 PM	0.35
4/10/2025	4:45:00 PM	0.35
4/10/2025	5:00:00 PM	0.35
4/10/2025	5:15:00 PM	0.35
4/10/2025	5:30:00 PM	0.35
4/10/2025	5:45:00 PM	0.35
4/10/2025	6:00:00 PM	0.35
4/10/2025	6:15:00 PM	0.34
4/10/2025	6:30:00 PM	0.35
4/10/2025	6:45:00 PM	0.35
4/10/2025	7:00:00 PM	0.35
4/10/2025	7:15:00 PM	0.35
4/10/2025	7:30:00 PM	0.35
4/10/2025	7:45:00 PM	0.35
4/10/2025	8:00:00 PM	0.35
4/10/2025	8:15:00 PM	0.35
4/10/2025	8:30:00 PM	0.35
4/10/2025	8:45:00 PM	0.35
4/10/2025	9:00:00 PM	0.35
4/10/2025	9:15:00 PM	0.35
4/10/2025	9:30:00 PM	0.35
4/10/2025	9:45:00 PM	0.35
4/10/2025	10:00:00 PM	0.35
4/10/2025	10:15:00 PM	0.35
4/10/2025	10:30:00 PM	0.35
4/10/2025	10:45:00 PM	0.35
4/10/2025	11:00:00 PM	0.35
4/10/2025	11:15:00 PM	0.35
4/10/2025	11:30:00 PM	0.35
4/10/2025	11:45:00 PM	0.35
4/11/2025	12:00:00 AM	0.34
4/11/2025	12:15:00 AM	0.34
4/11/2025	12:30:00 AM	0.34
4/11/2025	12:45:00 AM	0.35
4/11/2025	1:00:00 AM	0.34
4/11/2025	1:15:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
4/11/2025	1:30:00 AM	0.34
4/11/2025	1:45:00 AM	0.34
4/11/2025	2:00:00 AM	0.35
4/11/2025	2:15:00 AM	0.34
4/11/2025	2:30:00 AM	0.34
4/11/2025	2:45:00 AM	0.34
4/11/2025	3:00:00 AM	0.34
4/11/2025	3:15:00 AM	0.34
4/11/2025	3:30:00 AM	0.34
4/11/2025	3:45:00 AM	0.34
4/11/2025	4:00:00 AM	0.34
4/11/2025	4:15:00 AM	0.34
4/11/2025	4:30:00 AM	0.34
4/11/2025	4:45:00 AM	0.34
4/11/2025	5:00:00 AM	0.34
4/11/2025	5:15:00 AM	0.34
4/11/2025	5:30:00 AM	0.34
4/11/2025	5:45:00 AM	0.34
4/11/2025	6:00:00 AM	0.34
4/11/2025	6:15:00 AM	0.34
4/11/2025	6:30:00 AM	0.34
4/11/2025	6:45:00 AM	0.34
4/11/2025	7:00:00 AM	0.34
4/11/2025	7:15:00 AM	0.34
4/11/2025	7:30:00 AM	0.34
4/11/2025	7:45:00 AM	0.34
4/11/2025	8:00:00 AM	0.34
4/11/2025	8:15:00 AM	0.34
4/11/2025	8:30:00 AM	0.34
4/11/2025	8:45:00 AM	0.34
4/11/2025	9:00:00 AM	0.34
4/11/2025	9:15:00 AM	0.35
4/11/2025	9:30:00 AM	0.35
4/11/2025	9:45:00 AM	0.35
4/11/2025	10:00:00 AM	0.35
4/11/2025	10:15:00 AM	0.35
4/11/2025	10:30:00 AM	0.35
4/11/2025	10:45:00 AM	0.35
4/11/2025	11:00:00 AM	0.35
4/11/2025	11:15:00 AM	0.35
4/11/2025	11:30:00 AM	0.35
4/11/2025	11:45:00 AM	0.35
4/11/2025	12:00:00 PM	0.35
4/11/2025	12:15:00 PM	0.34
4/11/2025	12:30:00 PM	0.35
4/11/2025	12:45:00 PM	0.35

Billy Lake Return Gage

DATE	TIME	GAGE
4/11/2025	1:00:00 PM	0.35
4/11/2025	1:15:00 PM	0.35
4/11/2025	1:30:00 PM	0.35
4/11/2025	1:45:00 PM	0.34
4/11/2025	2:00:00 PM	0.35
4/11/2025	2:15:00 PM	0.34
4/11/2025	2:30:00 PM	0.34
4/11/2025	2:45:00 PM	0.34
4/11/2025	3:00:00 PM	0.34
4/11/2025	3:15:00 PM	0.34
4/11/2025	3:30:00 PM	0.34
4/11/2025	3:45:00 PM	0.34
4/11/2025	4:00:00 PM	0.35
4/11/2025	4:15:00 PM	0.35
4/11/2025	4:30:00 PM	0.34
4/11/2025	4:45:00 PM	0.34
4/11/2025	5:00:00 PM	0.34
4/11/2025	5:15:00 PM	0.34
4/11/2025	5:30:00 PM	0.34
4/11/2025	5:45:00 PM	0.34
4/11/2025	6:00:00 PM	0.34
4/11/2025	6:15:00 PM	0.34
4/11/2025	6:30:00 PM	0.35
4/11/2025	6:45:00 PM	0.35
4/11/2025	7:00:00 PM	0.35
4/11/2025	7:15:00 PM	0.35
4/11/2025	7:30:00 PM	0.35
4/11/2025	7:45:00 PM	0.35
4/11/2025	8:00:00 PM	0.35
4/11/2025	8:15:00 PM	0.35
4/11/2025	8:30:00 PM	0.35
4/11/2025	8:45:00 PM	0.35
4/11/2025	9:00:00 PM	0.35
4/11/2025	9:15:00 PM	0.35
4/11/2025	9:30:00 PM	0.35
4/11/2025	9:45:00 PM	0.35
4/11/2025	10:00:00 PM	0.35
4/11/2025	10:15:00 PM	0.35
4/11/2025	10:30:00 PM	0.35
4/11/2025	10:45:00 PM	0.35
4/11/2025	11:00:00 PM	0.35
4/11/2025	11:15:00 PM	0.35
4/11/2025	11:30:00 PM	0.35
4/11/2025	11:45:00 PM	0.35
4/12/2025	12:00:00 AM	0.35
4/12/2025	12:15:00 AM	0.35

Billy Lake Return Gage

DATE	TIME	GAGE
4/12/2025	12:30:00 AM	0.35
4/12/2025	12:45:00 AM	0.35
4/12/2025	1:00:00 AM	0.35
4/12/2025	1:15:00 AM	0.35
4/12/2025	1:30:00 AM	0.35
4/12/2025	1:45:00 AM	0.35
4/12/2025	2:00:00 AM	0.35
4/12/2025	2:15:00 AM	0.35
4/12/2025	2:30:00 AM	0.35
4/12/2025	2:45:00 AM	0.35
4/12/2025	3:00:00 AM	0.35
4/12/2025	3:15:00 AM	0.35
4/12/2025	3:30:00 AM	0.35
4/12/2025	3:45:00 AM	0.35
4/12/2025	4:00:00 AM	0.35
4/12/2025	4:15:00 AM	0.35
4/12/2025	4:30:00 AM	0.35
4/12/2025	4:45:00 AM	0.35
4/12/2025	5:00:00 AM	0.35
4/12/2025	5:15:00 AM	0.35
4/12/2025	5:30:00 AM	0.35
4/12/2025	5:45:00 AM	0.35
4/12/2025	6:00:00 AM	0.35
4/12/2025	6:15:00 AM	0.35
4/12/2025	6:30:00 AM	0.35
4/12/2025	6:45:00 AM	0.35
4/12/2025	7:00:00 AM	0.35
4/12/2025	7:15:00 AM	0.35
4/12/2025	7:30:00 AM	0.35
4/12/2025	7:45:00 AM	0.35
4/12/2025	8:00:00 AM	0.35
4/12/2025	8:15:00 AM	0.35
4/12/2025	8:30:00 AM	0.35
4/12/2025	8:45:00 AM	0.35
4/12/2025	9:00:00 AM	0.35
4/12/2025	9:15:00 AM	0.35
4/12/2025	9:30:00 AM	0.35
4/12/2025	9:45:00 AM	0.35
4/12/2025	10:00:00 AM	0.35
4/12/2025	10:15:00 AM	0.35
4/12/2025	10:30:00 AM	0.35
4/12/2025	10:45:00 AM	0.35
4/12/2025	11:00:00 AM	0.35
4/12/2025	11:15:00 AM	0.35
4/12/2025	11:30:00 AM	0.35
4/12/2025	11:45:00 AM	0.35

Billy Lake Return Gage

DATE	TIME	GAGE
4/12/2025	12:00:00 PM	0.35
4/12/2025	12:15:00 PM	0.35
4/12/2025	12:30:00 PM	0.35
4/12/2025	12:45:00 PM	0.35
4/12/2025	1:00:00 PM	0.35
4/12/2025	1:15:00 PM	0.35
4/12/2025	1:30:00 PM	0.35
4/12/2025	1:45:00 PM	0.35
4/12/2025	2:00:00 PM	0.35
4/12/2025	2:15:00 PM	0.35
4/12/2025	2:30:00 PM	0.35
4/12/2025	2:45:00 PM	0.35
4/12/2025	3:00:00 PM	0.35
4/12/2025	3:15:00 PM	0.35
4/12/2025	3:30:00 PM	0.35
4/12/2025	3:45:00 PM	0.35
4/12/2025	4:00:00 PM	0.35
4/12/2025	4:15:00 PM	0.35
4/12/2025	4:30:00 PM	0.35
4/12/2025	4:45:00 PM	0.35
4/12/2025	5:00:00 PM	0.35
4/12/2025	5:15:00 PM	0.35
4/12/2025	5:30:00 PM	0.35
4/12/2025	5:45:00 PM	0.35
4/12/2025	6:00:00 PM	0.35
4/12/2025	6:15:00 PM	0.35
4/12/2025	6:30:00 PM	0.35
4/12/2025	6:45:00 PM	0.35
4/12/2025	7:00:00 PM	0.35
4/12/2025	7:15:00 PM	0.35
4/12/2025	7:30:00 PM	0.35
4/12/2025	7:45:00 PM	0.35
4/12/2025	8:00:00 PM	0.35
4/12/2025	8:15:00 PM	0.35
4/12/2025	8:30:00 PM	0.35
4/12/2025	8:45:00 PM	0.35
4/12/2025	9:00:00 PM	0.35
4/12/2025	9:15:00 PM	0.35
4/12/2025	9:30:00 PM	0.35
4/12/2025	9:45:00 PM	0.35
4/12/2025	10:00:00 PM	0.35
4/12/2025	10:15:00 PM	0.35
4/12/2025	10:30:00 PM	0.35
4/12/2025	10:45:00 PM	0.35
4/12/2025	11:00:00 PM	0.35
4/12/2025	11:15:00 PM	0.35

Billy Lake Return Gage

DATE	TIME	GAGE
4/12/2025	11:30:00 PM	0.35
4/12/2025	11:45:00 PM	0.35
4/13/2025	12:00:00 AM	0.35
4/13/2025	12:15:00 AM	0.35
4/13/2025	12:30:00 AM	0.35
4/13/2025	12:45:00 AM	0.35
4/13/2025	1:00:00 AM	0.35
4/13/2025	1:15:00 AM	0.35
4/13/2025	1:30:00 AM	0.35
4/13/2025	1:45:00 AM	0.35
4/13/2025	2:00:00 AM	0.35
4/13/2025	2:15:00 AM	0.35
4/13/2025	2:30:00 AM	0.35
4/13/2025	2:45:00 AM	0.35
4/13/2025	3:00:00 AM	0.35
4/13/2025	3:15:00 AM	0.35
4/13/2025	3:30:00 AM	0.35
4/13/2025	3:45:00 AM	0.35
4/13/2025	4:00:00 AM	0.35
4/13/2025	4:15:00 AM	0.35
4/13/2025	4:30:00 AM	0.35
4/13/2025	4:45:00 AM	0.35
4/13/2025	5:00:00 AM	0.35
4/13/2025	5:15:00 AM	0.35
4/13/2025	5:30:00 AM	0.35
4/13/2025	5:45:00 AM	0.35
4/13/2025	6:00:00 AM	0.35
4/13/2025	6:15:00 AM	0.35
4/13/2025	6:30:00 AM	0.35
4/13/2025	6:45:00 AM	0.35
4/13/2025	7:00:00 AM	0.35
4/13/2025	7:15:00 AM	0.35
4/13/2025	7:30:00 AM	0.35
4/13/2025	7:45:00 AM	0.35
4/13/2025	8:00:00 AM	0.35
4/13/2025	8:15:00 AM	0.35
4/13/2025	8:30:00 AM	0.35
4/13/2025	8:45:00 AM	0.35
4/13/2025	9:00:00 AM	0.35
4/13/2025	9:15:00 AM	0.35
4/13/2025	9:30:00 AM	0.35
4/13/2025	9:45:00 AM	0.35
4/13/2025	10:00:00 AM	0.35
4/13/2025	10:15:00 AM	0.35
4/13/2025	10:30:00 AM	0.35
4/13/2025	10:45:00 AM	0.35

Billy Lake Return Gage

DATE	TIME	GAGE
4/13/2025	11:00:00 AM	0.35
4/13/2025	11:15:00 AM	0.35
4/13/2025	11:30:00 AM	0.35
4/13/2025	11:45:00 AM	0.35
4/13/2025	12:00:00 PM	0.35
4/13/2025	12:15:00 PM	0.35
4/13/2025	12:30:00 PM	0.35
4/13/2025	12:45:00 PM	0.35
4/13/2025	1:00:00 PM	0.35
4/13/2025	1:15:00 PM	0.35
4/13/2025	1:30:00 PM	0.35
4/13/2025	1:45:00 PM	0.35
4/13/2025	2:00:00 PM	0.34
4/13/2025	2:15:00 PM	0.34
4/13/2025	2:30:00 PM	0.34
4/13/2025	2:45:00 PM	0.34
4/13/2025	3:00:00 PM	0.34
4/13/2025	3:15:00 PM	0.34
4/13/2025	3:30:00 PM	0.34
4/13/2025	3:45:00 PM	0.34
4/13/2025	4:00:00 PM	0.34
4/13/2025	4:15:00 PM	0.34
4/13/2025	4:30:00 PM	0.34
4/13/2025	4:45:00 PM	0.34
4/13/2025	5:00:00 PM	0.34
4/13/2025	5:15:00 PM	0.34
4/13/2025	5:30:00 PM	0.34
4/13/2025	5:45:00 PM	0.34
4/13/2025	6:00:00 PM	0.34
4/13/2025	6:15:00 PM	0.34
4/13/2025	6:30:00 PM	0.34
4/13/2025	6:45:00 PM	0.34
4/13/2025	7:00:00 PM	0.34
4/13/2025	7:15:00 PM	0.34
4/13/2025	7:30:00 PM	0.34
4/13/2025	7:45:00 PM	0.34
4/13/2025	8:00:00 PM	0.34
4/13/2025	8:15:00 PM	0.34
4/13/2025	8:30:00 PM	0.34
4/13/2025	8:45:00 PM	0.34
4/13/2025	9:00:00 PM	0.34
4/13/2025	9:15:00 PM	0.34
4/13/2025	9:30:00 PM	0.34
4/13/2025	9:45:00 PM	0.34
4/13/2025	10:00:00 PM	0.34
4/13/2025	10:15:00 PM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
4/13/2025	10:30:00 PM	0.34
4/13/2025	10:45:00 PM	0.34
4/13/2025	11:00:00 PM	0.34
4/13/2025	11:15:00 PM	0.34
4/13/2025	11:30:00 PM	0.34
4/13/2025	11:45:00 PM	0.34
4/14/2025	12:00:00 AM	0.34
4/14/2025	12:15:00 AM	0.34
4/14/2025	12:30:00 AM	0.34
4/14/2025	12:45:00 AM	0.34
4/14/2025	1:00:00 AM	0.34
4/14/2025	1:15:00 AM	0.34
4/14/2025	1:30:00 AM	0.34
4/14/2025	1:45:00 AM	0.34
4/14/2025	2:00:00 AM	0.34
4/14/2025	2:15:00 AM	0.34
4/14/2025	2:30:00 AM	0.34
4/14/2025	2:45:00 AM	0.34
4/14/2025	3:00:00 AM	0.34
4/14/2025	3:15:00 AM	0.34
4/14/2025	3:30:00 AM	0.34
4/14/2025	3:45:00 AM	0.33
4/14/2025	4:00:00 AM	0.34
4/14/2025	4:15:00 AM	0.34
4/14/2025	4:30:00 AM	0.34
4/14/2025	4:45:00 AM	0.34
4/14/2025	5:00:00 AM	0.34
4/14/2025	5:15:00 AM	0.34
4/14/2025	5:30:00 AM	0.34
4/14/2025	5:45:00 AM	0.33
4/14/2025	6:00:00 AM	0.33
4/14/2025	6:15:00 AM	0.34
4/14/2025	6:30:00 AM	0.34
4/14/2025	6:45:00 AM	0.34
4/14/2025	7:00:00 AM	0.34
4/14/2025	7:15:00 AM	0.34
4/14/2025	7:30:00 AM	0.34
4/14/2025	7:45:00 AM	0.34
4/14/2025	8:00:00 AM	0.34
4/14/2025	8:15:00 AM	0.34
4/14/2025	8:30:00 AM	0.34
4/14/2025	8:45:00 AM	0.34
4/14/2025	9:00:00 AM	0.34
4/14/2025	9:15:00 AM	0.34
4/14/2025	9:30:00 AM	0.34
4/14/2025	9:45:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
4/14/2025	10:00:00 AM	0.34
4/14/2025	10:15:00 AM	0.35
4/14/2025	10:30:00 AM	0.34
4/14/2025	10:45:00 AM	0.35
4/14/2025	11:00:00 AM	0.35
4/14/2025	11:15:00 AM	0.35
4/14/2025	11:30:00 AM	0.35
4/14/2025	11:45:00 AM	0.35
4/14/2025	12:00:00 PM	0.35
4/14/2025	12:15:00 PM	0.35
4/14/2025	12:30:00 PM	0.35
4/14/2025	12:45:00 PM	0.35
4/14/2025	1:00:00 PM	0.35
4/14/2025	1:15:00 PM	0.35
4/14/2025	1:30:00 PM	0.35
4/14/2025	1:45:00 PM	0.35
4/14/2025	2:00:00 PM	0.35
4/14/2025	2:15:00 PM	0.35
4/14/2025	2:30:00 PM	0.35
4/14/2025	2:45:00 PM	0.35
4/14/2025	3:00:00 PM	0.35
4/14/2025	3:15:00 PM	0.35
4/14/2025	3:30:00 PM	0.35
4/14/2025	3:45:00 PM	0.35
4/14/2025	4:00:00 PM	0.35
4/14/2025	4:15:00 PM	0.35
4/14/2025	4:30:00 PM	0.35
4/14/2025	4:45:00 PM	0.35
4/14/2025	5:00:00 PM	0.35
4/14/2025	5:15:00 PM	0.35
4/14/2025	5:30:00 PM	0.35
4/14/2025	5:45:00 PM	0.35
4/14/2025	6:00:00 PM	0.35
4/14/2025	6:15:00 PM	0.35
4/14/2025	6:30:00 PM	0.35
4/14/2025	6:45:00 PM	0.35
4/14/2025	7:00:00 PM	0.35
4/14/2025	7:15:00 PM	0.35
4/14/2025	7:30:00 PM	0.35
4/14/2025	7:45:00 PM	0.35
4/14/2025	8:00:00 PM	0.35
4/14/2025	8:15:00 PM	0.35
4/14/2025	8:30:00 PM	0.35
4/14/2025	8:45:00 PM	0.35
4/14/2025	9:00:00 PM	0.35
4/14/2025	9:15:00 PM	0.35

Billy Lake Return Gage

DATE	TIME	GAGE
4/14/2025	9:30:00 PM	0.35
4/14/2025	9:45:00 PM	0.35
4/14/2025	10:00:00 PM	0.35
4/14/2025	10:15:00 PM	0.35
4/14/2025	10:30:00 PM	0.35
4/14/2025	10:45:00 PM	0.34
4/14/2025	11:00:00 PM	0.34
4/14/2025	11:15:00 PM	0.34
4/14/2025	11:30:00 PM	0.34
4/14/2025	11:45:00 PM	0.34
4/15/2025	12:00:00 AM	0.33
4/15/2025	12:15:00 AM	0.34
4/15/2025	12:30:00 AM	0.34
4/15/2025	12:45:00 AM	0.34
4/15/2025	1:00:00 AM	0.34
4/15/2025	1:15:00 AM	0.34
4/15/2025	1:30:00 AM	0.34
4/15/2025	1:45:00 AM	0.34
4/15/2025	2:00:00 AM	0.34
4/15/2025	2:15:00 AM	0.34
4/15/2025	2:30:00 AM	0.34
4/15/2025	2:45:00 AM	0.33
4/15/2025	3:00:00 AM	0.33
4/15/2025	3:15:00 AM	0.33
4/15/2025	3:30:00 AM	0.34
4/15/2025	3:45:00 AM	0.33
4/15/2025	4:00:00 AM	0.33
4/15/2025	4:15:00 AM	0.33
4/15/2025	4:30:00 AM	0.33
4/15/2025	4:45:00 AM	0.33
4/15/2025	5:00:00 AM	0.33
4/15/2025	5:15:00 AM	0.33
4/15/2025	5:30:00 AM	0.33
4/15/2025	5:45:00 AM	0.33
4/15/2025	6:00:00 AM	0.33
4/15/2025	6:15:00 AM	0.33
4/15/2025	6:30:00 AM	0.33
4/15/2025	6:45:00 AM	0.33
4/15/2025	7:00:00 AM	0.33
4/15/2025	7:15:00 AM	0.33
4/15/2025	7:30:00 AM	0.33
4/15/2025	7:45:00 AM	0.33
4/15/2025	8:00:00 AM	0.33
4/15/2025	8:15:00 AM	0.33
4/15/2025	8:30:00 AM	0.33
4/15/2025	8:45:00 AM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
4/15/2025	9:00:00 AM	0.33
4/15/2025	9:15:00 AM	0.33
4/15/2025	9:30:00 AM	0.33
4/15/2025	9:45:00 AM	0.33
4/15/2025	10:00:00 AM	0.33
4/15/2025	10:15:00 AM	0.33
4/15/2025	10:30:00 AM	0.33
4/15/2025	10:45:00 AM	0.33
4/15/2025	11:00:00 AM	0.33
4/15/2025	11:15:00 AM	0.33
4/15/2025	11:30:00 AM	0.33
4/15/2025	11:45:00 AM	0.33
4/15/2025	12:00:00 PM	0.33
4/15/2025	12:15:00 PM	0.33
4/15/2025	12:30:00 PM	0.33
4/15/2025	12:45:00 PM	0.33
4/15/2025	1:00:00 PM	0.33
4/15/2025	1:15:00 PM	0.33
4/15/2025	1:30:00 PM	0.33
4/15/2025	1:45:00 PM	0.33
4/15/2025	2:00:00 PM	0.32
4/15/2025	2:15:00 PM	0.32
4/15/2025	2:30:00 PM	0.32
4/15/2025	2:45:00 PM	0.32
4/15/2025	3:00:00 PM	0.32
4/15/2025	3:15:00 PM	0.32
4/15/2025	3:30:00 PM	0.32
4/15/2025	3:45:00 PM	0.32
4/15/2025	4:00:00 PM	0.32
4/15/2025	4:15:00 PM	0.32
4/15/2025	4:30:00 PM	0.32
4/15/2025	4:45:00 PM	0.32
4/15/2025	5:00:00 PM	0.32
4/15/2025	5:15:00 PM	0.32
4/15/2025	5:30:00 PM	0.32
4/15/2025	5:45:00 PM	0.32
4/15/2025	6:00:00 PM	0.32
4/15/2025	6:15:00 PM	0.32
4/15/2025	6:30:00 PM	0.31
4/15/2025	6:45:00 PM	0.31
4/15/2025	7:00:00 PM	0.31
4/15/2025	7:15:00 PM	0.31
4/15/2025	7:30:00 PM	0.31
4/15/2025	7:45:00 PM	0.31
4/15/2025	8:00:00 PM	0.31
4/15/2025	8:15:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
4/15/2025	8:30:00 PM	0.31
4/15/2025	8:45:00 PM	0.31
4/15/2025	9:00:00 PM	0.31
4/15/2025	9:15:00 PM	0.31
4/15/2025	9:30:00 PM	0.31
4/15/2025	9:45:00 PM	0.31
4/15/2025	10:00:00 PM	0.31
4/15/2025	10:15:00 PM	0.31
4/15/2025	10:30:00 PM	0.31
4/15/2025	10:45:00 PM	0.31
4/15/2025	11:00:00 PM	0.31
4/15/2025	11:15:00 PM	0.31
4/15/2025	11:30:00 PM	0.31
4/15/2025	11:45:00 PM	0.31
4/16/2025	12:00:00 AM	0.31
4/16/2025	12:15:00 AM	0.31
4/16/2025	12:30:00 AM	0.31
4/16/2025	12:45:00 AM	0.31
4/16/2025	1:00:00 AM	0.31
4/16/2025	1:15:00 AM	0.31
4/16/2025	1:30:00 AM	0.31
4/16/2025	1:45:00 AM	0.31
4/16/2025	2:00:00 AM	0.31
4/16/2025	2:15:00 AM	0.31
4/16/2025	2:30:00 AM	0.31
4/16/2025	2:45:00 AM	0.31
4/16/2025	3:00:00 AM	0.31
4/16/2025	3:15:00 AM	0.31
4/16/2025	3:30:00 AM	0.31
4/16/2025	3:45:00 AM	0.31
4/16/2025	4:00:00 AM	0.31
4/16/2025	4:15:00 AM	0.31
4/16/2025	4:30:00 AM	0.31
4/16/2025	4:45:00 AM	0.31
4/16/2025	5:00:00 AM	0.31
4/16/2025	5:15:00 AM	0.31
4/16/2025	5:30:00 AM	0.31
4/16/2025	5:45:00 AM	0.31
4/16/2025	6:00:00 AM	0.31
4/16/2025	6:15:00 AM	0.31
4/16/2025	6:30:00 AM	0.32
4/16/2025	6:45:00 AM	0.32
4/16/2025	7:00:00 AM	0.32
4/16/2025	7:15:00 AM	0.32
4/16/2025	7:30:00 AM	0.32
4/16/2025	7:45:00 AM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
4/16/2025	8:00:00 AM	0.32
4/16/2025	8:15:00 AM	0.32
4/16/2025	8:30:00 AM	0.32
4/16/2025	8:45:00 AM	0.32
4/16/2025	9:00:00 AM	0.32
4/16/2025	9:15:00 AM	0.32
4/16/2025	9:30:00 AM	0.32
4/16/2025	9:45:00 AM	0.32
4/16/2025	10:00:00 AM	0.32
4/16/2025	10:15:00 AM	0.32
4/16/2025	10:30:00 AM	0.32
4/16/2025	10:45:00 AM	0.32
4/16/2025	11:00:00 AM	0.32
4/16/2025	11:15:00 AM	0.32
4/16/2025	11:30:00 AM	0.32
4/16/2025	11:45:00 AM	0.32
4/16/2025	12:00:00 PM	0.32
4/16/2025	12:15:00 PM	0.32
4/16/2025	12:30:00 PM	0.32
4/16/2025	12:45:00 PM	0.32
4/16/2025	1:00:00 PM	0.32
4/16/2025	1:15:00 PM	0.32
4/16/2025	1:30:00 PM	0.32
4/16/2025	1:45:00 PM	0.32
4/16/2025	2:00:00 PM	0.32
4/16/2025	2:15:00 PM	0.32
4/16/2025	2:30:00 PM	0.32
4/16/2025	2:45:00 PM	0.32
4/16/2025	3:00:00 PM	0.32
4/16/2025	3:15:00 PM	0.32
4/16/2025	3:30:00 PM	0.32
4/16/2025	3:45:00 PM	0.32
4/16/2025	4:00:00 PM	0.32
4/16/2025	4:15:00 PM	0.32
4/16/2025	4:30:00 PM	0.31
4/16/2025	4:45:00 PM	0.31
4/16/2025	5:00:00 PM	0.31
4/16/2025	5:15:00 PM	0.31
4/16/2025	5:30:00 PM	0.31
4/16/2025	5:45:00 PM	0.31
4/16/2025	6:00:00 PM	0.31
4/16/2025	6:15:00 PM	0.31
4/16/2025	6:30:00 PM	0.31
4/16/2025	6:45:00 PM	0.31
4/16/2025	7:00:00 PM	0.31
4/16/2025	7:15:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
4/16/2025	7:30:00 PM	0.31
4/16/2025	7:45:00 PM	0.31
4/16/2025	8:00:00 PM	0.31
4/16/2025	8:15:00 PM	0.31
4/16/2025	8:30:00 PM	0.31
4/16/2025	8:45:00 PM	0.31
4/16/2025	9:00:00 PM	0.31
4/16/2025	9:15:00 PM	0.31
4/16/2025	9:30:00 PM	0.31
4/16/2025	9:45:00 PM	0.31
4/16/2025	10:00:00 PM	0.31
4/16/2025	10:15:00 PM	0.31
4/16/2025	10:30:00 PM	0.31
4/16/2025	10:45:00 PM	0.31
4/16/2025	11:00:00 PM	0.31
4/16/2025	11:15:00 PM	0.31
4/16/2025	11:30:00 PM	0.31
4/16/2025	11:45:00 PM	0.31
4/17/2025	12:00:00 AM	0.31
4/17/2025	12:15:00 AM	0.31
4/17/2025	12:30:00 AM	0.31
4/17/2025	12:45:00 AM	0.31
4/17/2025	1:00:00 AM	0.31
4/17/2025	1:15:00 AM	0.31
4/17/2025	1:30:00 AM	0.31
4/17/2025	1:45:00 AM	0.31
4/17/2025	2:00:00 AM	0.31
4/17/2025	2:15:00 AM	0.31
4/17/2025	2:30:00 AM	0.31
4/17/2025	2:45:00 AM	0.31
4/17/2025	3:00:00 AM	0.31
4/17/2025	3:15:00 AM	0.31
4/17/2025	3:30:00 AM	0.31
4/17/2025	3:45:00 AM	0.31
4/17/2025	4:00:00 AM	0.31
4/17/2025	4:15:00 AM	0.31
4/17/2025	4:30:00 AM	0.31
4/17/2025	4:45:00 AM	0.31
4/17/2025	5:00:00 AM	0.31
4/17/2025	5:15:00 AM	0.31
4/17/2025	5:30:00 AM	0.31
4/17/2025	5:45:00 AM	0.31
4/17/2025	6:00:00 AM	0.31
4/17/2025	6:15:00 AM	0.31
4/17/2025	6:30:00 AM	0.31
4/17/2025	6:45:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
4/17/2025	7:00:00 AM	0.31
4/17/2025	7:15:00 AM	0.31
4/17/2025	7:30:00 AM	0.31
4/17/2025	7:45:00 AM	0.31
4/17/2025	8:00:00 AM	0.32
4/17/2025	8:15:00 AM	0.32
4/17/2025	8:30:00 AM	0.32
4/17/2025	8:45:00 AM	0.32
4/17/2025	9:00:00 AM	0.32
4/17/2025	9:15:00 AM	0.32
4/17/2025	9:30:00 AM	0.32
4/17/2025	9:45:00 AM	0.32
4/17/2025	10:00:00 AM	0.32
4/17/2025	10:15:00 AM	0.32
4/17/2025	10:30:00 AM	0.32
4/17/2025	10:45:00 AM	0.32
4/17/2025	11:00:00 AM	0.32
4/17/2025	11:15:00 AM	0.32
4/17/2025	11:30:00 AM	0.32
4/17/2025	11:45:00 AM	0.32
4/17/2025	12:00:00 PM	0.32
4/17/2025	12:15:00 PM	0.32
4/17/2025	12:30:00 PM	0.32
4/17/2025	12:45:00 PM	0.32
4/17/2025	1:00:00 PM	0.32
4/17/2025	1:15:00 PM	0.32
4/17/2025	1:30:00 PM	0.32
4/17/2025	1:45:00 PM	0.32
4/17/2025	2:00:00 PM	0.32
4/17/2025	2:15:00 PM	0.32
4/17/2025	2:30:00 PM	0.32
4/17/2025	2:45:00 PM	0.31
4/17/2025	3:00:00 PM	0.31
4/17/2025	3:15:00 PM	0.31
4/17/2025	3:30:00 PM	0.31
4/17/2025	3:45:00 PM	0.31
4/17/2025	4:00:00 PM	0.31
4/17/2025	4:15:00 PM	0.3
4/17/2025	4:30:00 PM	0.3
4/17/2025	4:45:00 PM	0.3
4/17/2025	5:00:00 PM	0.3
4/17/2025	5:15:00 PM	0.3
4/17/2025	5:30:00 PM	0.3
4/17/2025	5:45:00 PM	0.3
4/17/2025	6:00:00 PM	0.3
4/17/2025	6:15:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
4/17/2025	6:30:00 PM	0.3
4/17/2025	6:45:00 PM	0.3
4/17/2025	7:00:00 PM	0.29
4/17/2025	7:15:00 PM	0.29
4/17/2025	7:30:00 PM	0.29
4/17/2025	7:45:00 PM	0.29
4/17/2025	8:00:00 PM	0.29
4/17/2025	8:15:00 PM	0.29
4/17/2025	8:30:00 PM	0.29
4/17/2025	8:45:00 PM	0.29
4/17/2025	9:00:00 PM	0.29
4/17/2025	9:15:00 PM	0.29
4/17/2025	9:30:00 PM	0.29
4/17/2025	9:45:00 PM	0.29
4/17/2025	10:00:00 PM	0.29
4/17/2025	10:15:00 PM	0.29
4/17/2025	10:30:00 PM	0.29
4/17/2025	10:45:00 PM	0.29
4/17/2025	11:00:00 PM	0.29
4/17/2025	11:15:00 PM	0.29
4/17/2025	11:30:00 PM	0.29
4/17/2025	11:45:00 PM	0.29
4/18/2025	12:00:00 AM	0.29
4/18/2025	12:15:00 AM	0.29
4/18/2025	12:30:00 AM	0.28
4/18/2025	12:45:00 AM	0.28
4/18/2025	1:00:00 AM	0.28
4/18/2025	1:15:00 AM	0.28
4/18/2025	1:30:00 AM	0.28
4/18/2025	1:45:00 AM	0.28
4/18/2025	2:00:00 AM	0.28
4/18/2025	2:15:00 AM	0.28
4/18/2025	2:30:00 AM	0.28
4/18/2025	2:45:00 AM	0.28
4/18/2025	3:00:00 AM	0.28
4/18/2025	3:15:00 AM	0.28
4/18/2025	3:30:00 AM	0.28
4/18/2025	3:45:00 AM	0.28
4/18/2025	4:00:00 AM	0.28
4/18/2025	4:15:00 AM	0.28
4/18/2025	4:30:00 AM	0.28
4/18/2025	4:45:00 AM	0.28
4/18/2025	5:00:00 AM	0.28
4/18/2025	5:15:00 AM	0.28
4/18/2025	5:30:00 AM	0.28
4/18/2025	5:45:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
4/18/2025	6:00:00 AM	0.28
4/18/2025	6:15:00 AM	0.28
4/18/2025	6:30:00 AM	0.28
4/18/2025	6:45:00 AM	0.28
4/18/2025	7:00:00 AM	0.28
4/18/2025	7:15:00 AM	0.28
4/18/2025	7:30:00 AM	0.28
4/18/2025	7:45:00 AM	0.28
4/18/2025	8:00:00 AM	0.28
4/18/2025	8:15:00 AM	0.28
4/18/2025	8:30:00 AM	0.28
4/18/2025	8:45:00 AM	0.27
4/18/2025	9:00:00 AM	0.27
4/18/2025	9:15:00 AM	0.27
4/18/2025	9:30:00 AM	0.27
4/18/2025	9:45:00 AM	0.27
4/18/2025	10:00:00 AM	0.27
4/18/2025	10:15:00 AM	0.27
4/18/2025	10:30:00 AM	0.26
4/18/2025	10:45:00 AM	0.26
4/18/2025	11:00:00 AM	0.26
4/18/2025	11:15:00 AM	0.26
4/18/2025	11:30:00 AM	0.26
4/18/2025	11:45:00 AM	0.26
4/18/2025	12:00:00 PM	0.26
4/18/2025	12:15:00 PM	0.26
4/18/2025	12:30:00 PM	0.26
4/18/2025	12:45:00 PM	0.26
4/18/2025	1:00:00 PM	0.26
4/18/2025	1:15:00 PM	0.26
4/18/2025	1:30:00 PM	0.27
4/18/2025	1:45:00 PM	0.27
4/18/2025	2:00:00 PM	0.27
4/18/2025	2:15:00 PM	0.27
4/18/2025	2:30:00 PM	0.27
4/18/2025	2:45:00 PM	0.28
4/18/2025	3:00:00 PM	0.28
4/18/2025	3:15:00 PM	0.28
4/18/2025	3:30:00 PM	0.28
4/18/2025	3:45:00 PM	0.28
4/18/2025	4:00:00 PM	0.28
4/18/2025	4:15:00 PM	0.28
4/18/2025	4:30:00 PM	0.29
4/18/2025	4:45:00 PM	0.29
4/18/2025	5:00:00 PM	0.29
4/18/2025	5:15:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
4/18/2025	5:30:00 PM	0.29
4/18/2025	5:45:00 PM	0.29
4/18/2025	6:00:00 PM	0.29
4/18/2025	6:15:00 PM	0.29
4/18/2025	6:30:00 PM	0.29
4/18/2025	6:45:00 PM	0.29
4/18/2025	7:00:00 PM	0.29
4/18/2025	7:15:00 PM	0.29
4/18/2025	7:30:00 PM	0.29
4/18/2025	7:45:00 PM	0.29
4/18/2025	8:00:00 PM	0.3
4/18/2025	8:15:00 PM	0.29
4/18/2025	8:30:00 PM	0.3
4/18/2025	8:45:00 PM	0.3
4/18/2025	9:00:00 PM	0.3
4/18/2025	9:15:00 PM	0.3
4/18/2025	9:30:00 PM	0.3
4/18/2025	9:45:00 PM	0.3
4/18/2025	10:00:00 PM	0.3
4/18/2025	10:15:00 PM	0.3
4/18/2025	10:30:00 PM	0.3
4/18/2025	10:45:00 PM	0.3
4/18/2025	11:00:00 PM	0.3
4/18/2025	11:15:00 PM	0.3
4/18/2025	11:30:00 PM	0.3
4/18/2025	11:45:00 PM	0.3
4/19/2025	12:00:00 AM	0.3
4/19/2025	12:15:00 AM	0.3
4/19/2025	12:30:00 AM	0.3
4/19/2025	12:45:00 AM	0.3
4/19/2025	1:00:00 AM	0.3
4/19/2025	1:15:00 AM	0.3
4/19/2025	1:30:00 AM	0.3
4/19/2025	1:45:00 AM	0.3
4/19/2025	2:00:00 AM	0.3
4/19/2025	2:15:00 AM	0.3
4/19/2025	2:30:00 AM	0.3
4/19/2025	2:45:00 AM	0.3
4/19/2025	3:00:00 AM	0.3
4/19/2025	3:15:00 AM	0.3
4/19/2025	3:30:00 AM	0.3
4/19/2025	3:45:00 AM	0.3
4/19/2025	4:00:00 AM	0.3
4/19/2025	4:15:00 AM	0.3
4/19/2025	4:30:00 AM	0.3
4/19/2025	4:45:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
4/19/2025	5:00:00 AM	0.3
4/19/2025	5:15:00 AM	0.3
4/19/2025	5:30:00 AM	0.3
4/19/2025	5:45:00 AM	0.3
4/19/2025	6:00:00 AM	0.3
4/19/2025	6:15:00 AM	0.3
4/19/2025	6:30:00 AM	0.3
4/19/2025	6:45:00 AM	0.3
4/19/2025	7:00:00 AM	0.3
4/19/2025	7:15:00 AM	0.3
4/19/2025	7:30:00 AM	0.3
4/19/2025	7:45:00 AM	0.3
4/19/2025	8:00:00 AM	0.3
4/19/2025	8:15:00 AM	0.3
4/19/2025	8:30:00 AM	0.3
4/19/2025	8:45:00 AM	0.3
4/19/2025	9:00:00 AM	0.3
4/19/2025	9:15:00 AM	0.31
4/19/2025	9:30:00 AM	0.3
4/19/2025	9:45:00 AM	0.3
4/19/2025	10:00:00 AM	0.31
4/19/2025	10:15:00 AM	0.3
4/19/2025	10:30:00 AM	0.3
4/19/2025	10:45:00 AM	0.3
4/19/2025	11:00:00 AM	0.3
4/19/2025	11:15:00 AM	0.3
4/19/2025	11:30:00 AM	0.3
4/19/2025	11:45:00 AM	0.3
4/19/2025	12:00:00 PM	0.3
4/19/2025	12:15:00 PM	0.3
4/19/2025	12:30:00 PM	0.3
4/19/2025	12:45:00 PM	0.3
4/19/2025	1:00:00 PM	0.3
4/19/2025	1:15:00 PM	0.3
4/19/2025	1:30:00 PM	0.31
4/19/2025	1:45:00 PM	0.31
4/19/2025	2:00:00 PM	0.31
4/19/2025	2:15:00 PM	0.31
4/19/2025	2:30:00 PM	0.31
4/19/2025	2:45:00 PM	0.31
4/19/2025	3:00:00 PM	0.31
4/19/2025	3:15:00 PM	0.31
4/19/2025	3:30:00 PM	0.31
4/19/2025	3:45:00 PM	0.31
4/19/2025	4:00:00 PM	0.31
4/19/2025	4:15:00 PM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
4/19/2025	4:30:00 PM	0.32
4/19/2025	4:45:00 PM	0.32
4/19/2025	5:00:00 PM	0.32
4/19/2025	5:15:00 PM	0.32
4/19/2025	5:30:00 PM	0.32
4/19/2025	5:45:00 PM	0.32
4/19/2025	6:00:00 PM	0.32
4/19/2025	6:15:00 PM	0.32
4/19/2025	6:30:00 PM	0.32
4/19/2025	6:45:00 PM	0.32
4/19/2025	7:00:00 PM	0.32
4/19/2025	7:15:00 PM	0.32
4/19/2025	7:30:00 PM	0.32
4/19/2025	7:45:00 PM	0.32
4/19/2025	8:00:00 PM	0.32
4/19/2025	8:15:00 PM	0.32
4/19/2025	8:30:00 PM	0.32
4/19/2025	8:45:00 PM	0.32
4/19/2025	9:00:00 PM	0.32
4/19/2025	9:15:00 PM	0.32
4/19/2025	9:30:00 PM	0.32
4/19/2025	9:45:00 PM	0.32
4/19/2025	10:00:00 PM	0.32
4/19/2025	10:15:00 PM	0.32
4/19/2025	10:30:00 PM	0.32
4/19/2025	10:45:00 PM	0.32
4/19/2025	11:00:00 PM	0.33
4/19/2025	11:15:00 PM	0.33
4/19/2025	11:30:00 PM	0.33
4/19/2025	11:45:00 PM	0.33
4/20/2025	12:00:00 AM	0.33
4/20/2025	12:15:00 AM	0.33
4/20/2025	12:30:00 AM	0.33
4/20/2025	12:45:00 AM	0.33
4/20/2025	1:00:00 AM	0.33
4/20/2025	1:15:00 AM	0.33
4/20/2025	1:30:00 AM	0.33
4/20/2025	1:45:00 AM	0.33
4/20/2025	2:00:00 AM	0.33
4/20/2025	2:15:00 AM	0.33
4/20/2025	2:30:00 AM	0.33
4/20/2025	2:45:00 AM	0.33
4/20/2025	3:00:00 AM	0.33
4/20/2025	3:15:00 AM	0.33
4/20/2025	3:30:00 AM	0.33
4/20/2025	3:45:00 AM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
4/20/2025	4:00:00 AM	0.33
4/20/2025	4:15:00 AM	0.33
4/20/2025	4:30:00 AM	0.33
4/20/2025	4:45:00 AM	0.33
4/20/2025	5:00:00 AM	0.33
4/20/2025	5:15:00 AM	0.33
4/20/2025	5:30:00 AM	0.33
4/20/2025	5:45:00 AM	0.33
4/20/2025	6:00:00 AM	0.33
4/20/2025	6:15:00 AM	0.33
4/20/2025	6:30:00 AM	0.33
4/20/2025	6:45:00 AM	0.33
4/20/2025	7:00:00 AM	0.33
4/20/2025	7:15:00 AM	0.33
4/20/2025	7:30:00 AM	0.33
4/20/2025	7:45:00 AM	0.33
4/20/2025	8:00:00 AM	0.33
4/20/2025	8:15:00 AM	0.33
4/20/2025	8:30:00 AM	0.33
4/20/2025	8:45:00 AM	0.33
4/20/2025	9:00:00 AM	0.33
4/20/2025	9:15:00 AM	0.33
4/20/2025	9:30:00 AM	0.33
4/20/2025	9:45:00 AM	0.33
4/20/2025	10:00:00 AM	0.33
4/20/2025	10:15:00 AM	0.33
4/20/2025	10:30:00 AM	0.33
4/20/2025	10:45:00 AM	0.33
4/20/2025	11:00:00 AM	0.33
4/20/2025	11:15:00 AM	0.33
4/20/2025	11:30:00 AM	0.33
4/20/2025	11:45:00 AM	0.33
4/20/2025	12:00:00 PM	0.33
4/20/2025	12:15:00 PM	0.33
4/20/2025	12:30:00 PM	0.33
4/20/2025	12:45:00 PM	0.33
4/20/2025	1:00:00 PM	0.33
4/20/2025	1:15:00 PM	0.33
4/20/2025	1:30:00 PM	0.33
4/20/2025	1:45:00 PM	0.33
4/20/2025	2:00:00 PM	0.33
4/20/2025	2:15:00 PM	0.33
4/20/2025	2:30:00 PM	0.33
4/20/2025	2:45:00 PM	0.33
4/20/2025	3:00:00 PM	0.33
4/20/2025	3:15:00 PM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
4/20/2025	3:30:00 PM	0.33
4/20/2025	3:45:00 PM	0.33
4/20/2025	4:00:00 PM	0.33
4/20/2025	4:15:00 PM	0.33
4/20/2025	4:30:00 PM	0.33
4/20/2025	4:45:00 PM	0.33
4/20/2025	5:00:00 PM	0.33
4/20/2025	5:15:00 PM	0.33
4/20/2025	5:30:00 PM	0.33
4/20/2025	5:45:00 PM	0.33
4/20/2025	6:00:00 PM	0.33
4/20/2025	6:15:00 PM	0.33
4/20/2025	6:30:00 PM	0.33
4/20/2025	6:45:00 PM	0.33
4/20/2025	7:00:00 PM	0.33
4/20/2025	7:15:00 PM	0.33
4/20/2025	7:30:00 PM	0.33
4/20/2025	7:45:00 PM	0.33
4/20/2025	8:00:00 PM	0.33
4/20/2025	8:15:00 PM	0.33
4/20/2025	8:30:00 PM	0.33
4/20/2025	8:45:00 PM	0.33
4/20/2025	9:00:00 PM	0.33
4/20/2025	9:15:00 PM	0.33
4/20/2025	9:30:00 PM	0.33
4/20/2025	9:45:00 PM	0.33
4/20/2025	10:00:00 PM	0.33
4/20/2025	10:15:00 PM	0.33
4/20/2025	10:30:00 PM	0.33
4/20/2025	10:45:00 PM	0.33
4/20/2025	11:00:00 PM	0.33
4/20/2025	11:15:00 PM	0.33
4/20/2025	11:30:00 PM	0.33
4/20/2025	11:45:00 PM	0.33
4/21/2025	12:00:00 AM	0.33
4/21/2025	12:15:00 AM	0.33
4/21/2025	12:30:00 AM	0.33
4/21/2025	12:45:00 AM	0.33
4/21/2025	1:00:00 AM	0.33
4/21/2025	1:15:00 AM	0.33
4/21/2025	1:30:00 AM	0.33
4/21/2025	1:45:00 AM	0.35
4/21/2025	2:00:00 AM	0.33
4/21/2025	2:15:00 AM	0.33
4/21/2025	2:30:00 AM	0.33
4/21/2025	2:45:00 AM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
4/21/2025	3:00:00 AM	0.33
4/21/2025	3:15:00 AM	0.33
4/21/2025	3:30:00 AM	0.33
4/21/2025	3:45:00 AM	0.33
4/21/2025	4:00:00 AM	0.33
4/21/2025	4:15:00 AM	0.33
4/21/2025	4:30:00 AM	0.33
4/21/2025	4:45:00 AM	0.33
4/21/2025	5:00:00 AM	0.33
4/21/2025	5:15:00 AM	0.33
4/21/2025	5:30:00 AM	0.33
4/21/2025	5:45:00 AM	0.33
4/21/2025	6:00:00 AM	0.33
4/21/2025	6:15:00 AM	0.33
4/21/2025	6:30:00 AM	0.33
4/21/2025	6:45:00 AM	0.33
4/21/2025	7:00:00 AM	0.33
4/21/2025	7:15:00 AM	0.33
4/21/2025	7:30:00 AM	0.33
4/21/2025	7:45:00 AM	0.33
4/21/2025	8:00:00 AM	0.33
4/21/2025	8:15:00 AM	0.33
4/21/2025	8:30:00 AM	0.33
4/21/2025	8:45:00 AM	0.33
4/21/2025	9:00:00 AM	0.33
4/21/2025	9:15:00 AM	0.33
4/21/2025	9:30:00 AM	0.33
4/21/2025	9:45:00 AM	0.33
4/21/2025	10:00:00 AM	0.33
4/21/2025	10:15:00 AM	0.33
4/21/2025	10:30:00 AM	0.33
4/21/2025	10:45:00 AM	0.33
4/21/2025	11:00:00 AM	0.33
4/21/2025	11:15:00 AM	0.33
4/21/2025	11:30:00 AM	0.33
4/21/2025	11:45:00 AM	0.33
4/21/2025	12:00:00 PM	0.33
4/21/2025	12:15:00 PM	0.33
4/21/2025	12:30:00 PM	0.33
4/21/2025	12:45:00 PM	0.33
4/21/2025	1:00:00 PM	0.33
4/21/2025	1:15:00 PM	0.33
4/21/2025	1:30:00 PM	0.33
4/21/2025	1:45:00 PM	0.33
4/21/2025	2:00:00 PM	0.33
4/21/2025	2:15:00 PM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
4/21/2025	2:30:00 PM	0.33
4/21/2025	2:45:00 PM	0.33
4/21/2025	3:00:00 PM	0.33
4/21/2025	3:15:00 PM	0.33
4/21/2025	3:30:00 PM	0.33
4/21/2025	3:45:00 PM	0.33
4/21/2025	4:00:00 PM	0.33
4/21/2025	4:15:00 PM	0.33
4/21/2025	4:30:00 PM	0.33
4/21/2025	4:45:00 PM	0.33
4/21/2025	5:00:00 PM	0.33
4/21/2025	5:15:00 PM	0.33
4/21/2025	5:30:00 PM	0.33
4/21/2025	5:45:00 PM	0.33
4/21/2025	6:00:00 PM	0.33
4/21/2025	6:15:00 PM	0.33
4/21/2025	6:30:00 PM	0.33
4/21/2025	6:45:00 PM	0.33
4/21/2025	7:00:00 PM	0.33
4/21/2025	7:15:00 PM	0.33
4/21/2025	7:30:00 PM	0.33
4/21/2025	7:45:00 PM	0.33
4/21/2025	8:00:00 PM	0.33
4/21/2025	8:15:00 PM	0.33
4/21/2025	8:30:00 PM	0.33
4/21/2025	8:45:00 PM	0.33
4/21/2025	9:00:00 PM	0.33
4/21/2025	9:15:00 PM	0.33
4/21/2025	9:30:00 PM	0.33
4/21/2025	9:45:00 PM	0.33
4/21/2025	10:00:00 PM	0.33
4/21/2025	10:15:00 PM	0.33
4/21/2025	10:30:00 PM	0.33
4/21/2025	10:45:00 PM	0.33
4/21/2025	11:00:00 PM	0.33
4/21/2025	11:15:00 PM	0.33
4/21/2025	11:30:00 PM	0.33
4/21/2025	11:45:00 PM	0.33
4/22/2025	12:00:00 AM	0.33
4/22/2025	12:15:00 AM	0.33
4/22/2025	12:30:00 AM	0.33
4/22/2025	12:45:00 AM	0.33
4/22/2025	1:00:00 AM	0.33
4/22/2025	1:15:00 AM	0.33
4/22/2025	1:30:00 AM	0.33
4/22/2025	1:45:00 AM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
4/22/2025	2:00:00 AM	0.33
4/22/2025	2:15:00 AM	0.33
4/22/2025	2:30:00 AM	0.33
4/22/2025	2:45:00 AM	0.33
4/22/2025	3:00:00 AM	0.33
4/22/2025	3:15:00 AM	0.33
4/22/2025	3:30:00 AM	0.33
4/22/2025	3:45:00 AM	0.33
4/22/2025	4:00:00 AM	0.33
4/22/2025	4:15:00 AM	0.33
4/22/2025	4:30:00 AM	0.33
4/22/2025	4:45:00 AM	0.33
4/22/2025	5:00:00 AM	0.33
4/22/2025	5:15:00 AM	0.33
4/22/2025	5:30:00 AM	0.33
4/22/2025	5:45:00 AM	0.33
4/22/2025	6:00:00 AM	0.33
4/22/2025	6:15:00 AM	0.33
4/22/2025	6:30:00 AM	0.33
4/22/2025	6:45:00 AM	0.33
4/22/2025	7:00:00 AM	0.33
4/22/2025	7:15:00 AM	0.33
4/22/2025	7:30:00 AM	0.33
4/22/2025	7:45:00 AM	0.33
4/22/2025	8:00:00 AM	0.33
4/22/2025	8:15:00 AM	0.33
4/22/2025	8:30:00 AM	0.33
4/22/2025	8:45:00 AM	0.33
4/22/2025	9:00:00 AM	0.33
4/22/2025	9:15:00 AM	0.33
4/22/2025	9:30:00 AM	0.33
4/22/2025	9:45:00 AM	0.33
4/22/2025	10:00:00 AM	0.33
4/22/2025	10:15:00 AM	0.33
4/22/2025	10:30:00 AM	0.33
4/22/2025	10:45:00 AM	0.33
4/22/2025	11:00:00 AM	0.33
4/22/2025	11:15:00 AM	0.33
4/22/2025	11:30:00 AM	0.33
4/22/2025	11:45:00 AM	0.33
4/22/2025	12:00:00 PM	0.33
4/22/2025	12:15:00 PM	0.33
4/22/2025	12:30:00 PM	0.33
4/22/2025	12:45:00 PM	0.33
4/22/2025	1:00:00 PM	0.33
4/22/2025	1:15:00 PM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
4/22/2025	1:30:00 PM	0.33
4/22/2025	1:45:00 PM	0.33
4/22/2025	2:00:00 PM	0.33
4/22/2025	2:15:00 PM	0.33
4/22/2025	2:30:00 PM	0.33
4/22/2025	2:45:00 PM	0.33
4/22/2025	3:00:00 PM	0.33
4/22/2025	3:15:00 PM	0.33
4/22/2025	3:30:00 PM	0.33
4/22/2025	3:45:00 PM	0.33
4/22/2025	4:00:00 PM	0.33
4/22/2025	4:15:00 PM	0.33
4/22/2025	4:30:00 PM	0.33
4/22/2025	4:45:00 PM	0.33
4/22/2025	5:00:00 PM	0.33
4/22/2025	5:15:00 PM	0.33
4/22/2025	5:30:00 PM	0.33
4/22/2025	5:45:00 PM	0.33
4/22/2025	6:00:00 PM	0.33
4/22/2025	6:15:00 PM	0.33
4/22/2025	6:30:00 PM	0.33
4/22/2025	6:45:00 PM	0.33
4/22/2025	7:00:00 PM	0.33
4/22/2025	7:15:00 PM	0.33
4/22/2025	7:30:00 PM	0.33
4/22/2025	7:45:00 PM	0.33
4/22/2025	8:00:00 PM	0.33
4/22/2025	8:15:00 PM	0.33
4/22/2025	8:30:00 PM	0.33
4/22/2025	8:45:00 PM	0.33
4/22/2025	9:00:00 PM	0.33
4/22/2025	9:15:00 PM	0.33
4/22/2025	9:30:00 PM	0.33
4/22/2025	9:45:00 PM	0.33
4/22/2025	10:00:00 PM	0.33
4/22/2025	10:15:00 PM	0.32
4/22/2025	10:30:00 PM	0.33
4/22/2025	10:45:00 PM	0.32
4/22/2025	11:00:00 PM	0.32
4/22/2025	11:15:00 PM	0.32
4/22/2025	11:30:00 PM	0.32
4/22/2025	11:45:00 PM	0.32
4/23/2025	12:00:00 AM	0.32
4/23/2025	12:15:00 AM	0.32
4/23/2025	12:30:00 AM	0.32
4/23/2025	12:45:00 AM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
4/23/2025	1:00:00 AM	0.32
4/23/2025	1:15:00 AM	0.32
4/23/2025	1:30:00 AM	0.32
4/23/2025	1:45:00 AM	0.32
4/23/2025	2:00:00 AM	0.32
4/23/2025	2:15:00 AM	0.32
4/23/2025	2:30:00 AM	0.32
4/23/2025	2:45:00 AM	0.32
4/23/2025	3:00:00 AM	0.32
4/23/2025	3:15:00 AM	0.32
4/23/2025	3:30:00 AM	0.32
4/23/2025	3:45:00 AM	0.32
4/23/2025	4:00:00 AM	0.32
4/23/2025	4:15:00 AM	0.32
4/23/2025	4:30:00 AM	0.32
4/23/2025	4:45:00 AM	0.32
4/23/2025	5:00:00 AM	0.32
4/23/2025	5:15:00 AM	0.33
4/23/2025	5:30:00 AM	0.32
4/23/2025	5:45:00 AM	0.32
4/23/2025	6:00:00 AM	0.32
4/23/2025	6:15:00 AM	0.32
4/23/2025	6:30:00 AM	0.32
4/23/2025	6:45:00 AM	0.32
4/23/2025	7:00:00 AM	0.32
4/23/2025	7:15:00 AM	0.32
4/23/2025	7:30:00 AM	0.33
4/23/2025	7:45:00 AM	0.33
4/23/2025	8:00:00 AM	0.33
4/23/2025	8:15:00 AM	0.33
4/23/2025	8:30:00 AM	0.33
4/23/2025	8:45:00 AM	0.33
4/23/2025	9:00:00 AM	0.33
4/23/2025	9:15:00 AM	0.33
4/23/2025	9:30:00 AM	0.33
4/23/2025	9:45:00 AM	0.33
4/23/2025	10:00:00 AM	0.33
4/23/2025	10:15:00 AM	0.33
4/23/2025	10:30:00 AM	0.33
4/23/2025	10:45:00 AM	0.33
4/23/2025	11:00:00 AM	0.33
4/23/2025	11:15:00 AM	0.33
4/23/2025	11:30:00 AM	0.33
4/23/2025	11:45:00 AM	0.33
4/23/2025	12:00:00 PM	0.33
4/23/2025	12:15:00 PM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
4/23/2025	12:30:00 PM	0.33
4/23/2025	12:45:00 PM	0.33
4/23/2025	1:00:00 PM	0.33
4/23/2025	1:15:00 PM	0.33
4/23/2025	1:30:00 PM	0.33
4/23/2025	1:45:00 PM	0.33
4/23/2025	2:00:00 PM	0.33
4/23/2025	2:15:00 PM	0.33
4/23/2025	2:30:00 PM	0.33
4/23/2025	2:45:00 PM	0.33
4/23/2025	3:00:00 PM	0.33
4/23/2025	3:15:00 PM	0.33
4/23/2025	3:30:00 PM	0.32
4/23/2025	3:45:00 PM	0.32
4/23/2025	4:00:00 PM	0.32
4/23/2025	4:15:00 PM	0.32
4/23/2025	4:30:00 PM	0.32
4/23/2025	4:45:00 PM	0.33
4/23/2025	5:00:00 PM	0.33
4/23/2025	5:15:00 PM	0.33
4/23/2025	5:30:00 PM	0.33
4/23/2025	5:45:00 PM	0.33
4/23/2025	6:00:00 PM	0.33
4/23/2025	6:15:00 PM	0.33
4/23/2025	6:30:00 PM	0.33
4/23/2025	6:45:00 PM	0.33
4/23/2025	7:00:00 PM	0.33
4/23/2025	7:15:00 PM	0.33
4/23/2025	7:30:00 PM	0.33
4/23/2025	7:45:00 PM	0.33
4/23/2025	8:00:00 PM	0.33
4/23/2025	8:15:00 PM	0.33
4/23/2025	8:30:00 PM	0.33
4/23/2025	8:45:00 PM	0.33
4/23/2025	9:00:00 PM	0.33
4/23/2025	9:15:00 PM	0.33
4/23/2025	9:30:00 PM	0.33
4/23/2025	9:45:00 PM	0.33
4/23/2025	10:00:00 PM	0.33
4/23/2025	10:15:00 PM	0.33
4/23/2025	10:30:00 PM	0.33
4/23/2025	10:45:00 PM	0.33
4/23/2025	11:00:00 PM	0.33
4/23/2025	11:15:00 PM	0.33
4/23/2025	11:30:00 PM	0.33
4/23/2025	11:45:00 PM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
4/24/2025	12:00:00 AM	0.33
4/24/2025	12:15:00 AM	0.33
4/24/2025	12:30:00 AM	0.33
4/24/2025	12:45:00 AM	0.33
4/24/2025	1:00:00 AM	0.33
4/24/2025	1:15:00 AM	0.33
4/24/2025	1:30:00 AM	0.33
4/24/2025	1:45:00 AM	0.33
4/24/2025	2:00:00 AM	0.33
4/24/2025	2:15:00 AM	0.33
4/24/2025	2:30:00 AM	0.33
4/24/2025	2:45:00 AM	0.33
4/24/2025	3:00:00 AM	0.33
4/24/2025	3:15:00 AM	0.33
4/24/2025	3:30:00 AM	0.33
4/24/2025	3:45:00 AM	0.33
4/24/2025	4:00:00 AM	0.33
4/24/2025	4:15:00 AM	0.33
4/24/2025	4:30:00 AM	0.33
4/24/2025	4:45:00 AM	0.33
4/24/2025	5:00:00 AM	0.33
4/24/2025	5:15:00 AM	0.33
4/24/2025	5:30:00 AM	0.33
4/24/2025	5:45:00 AM	0.33
4/24/2025	6:00:00 AM	0.33
4/24/2025	6:15:00 AM	0.33
4/24/2025	6:30:00 AM	0.33
4/24/2025	6:45:00 AM	0.33
4/24/2025	7:00:00 AM	0.33
4/24/2025	7:15:00 AM	0.33
4/24/2025	7:30:00 AM	0.33
4/24/2025	7:45:00 AM	0.33
4/24/2025	8:00:00 AM	0.33
4/24/2025	8:15:00 AM	0.33
4/24/2025	8:30:00 AM	0.33
4/24/2025	8:45:00 AM	0.33
4/24/2025	9:00:00 AM	0.33
4/24/2025	9:15:00 AM	0.33
4/24/2025	9:30:00 AM	0.34
4/24/2025	9:45:00 AM	0.34
4/24/2025	10:00:00 AM	0.33
4/24/2025	10:15:00 AM	0.34
4/24/2025	10:30:00 AM	0.34
4/24/2025	10:45:00 AM	0.34
4/24/2025	11:00:00 AM	0.34
4/24/2025	11:15:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
4/24/2025	11:30:00 AM	0.34
4/24/2025	11:45:00 AM	0.34
4/24/2025	12:00:00 PM	0.34
4/24/2025	12:15:00 PM	0.34
4/24/2025	12:30:00 PM	0.34
4/24/2025	12:45:00 PM	0.34
4/24/2025	1:00:00 PM	0.34
4/24/2025	1:15:00 PM	0.34
4/24/2025	1:30:00 PM	0.34
4/24/2025	1:45:00 PM	0.34
4/24/2025	2:00:00 PM	0.34
4/24/2025	2:15:00 PM	0.34
4/24/2025	2:30:00 PM	0.34
4/24/2025	2:45:00 PM	0.34
4/24/2025	3:00:00 PM	0.34
4/24/2025	3:15:00 PM	0.34
4/24/2025	3:30:00 PM	0.34
4/24/2025	3:45:00 PM	0.34
4/24/2025	4:00:00 PM	0.34
4/24/2025	4:15:00 PM	0.34
4/24/2025	4:30:00 PM	0.34
4/24/2025	4:45:00 PM	0.34
4/24/2025	5:00:00 PM	0.34
4/24/2025	5:15:00 PM	0.34
4/24/2025	5:30:00 PM	0.34
4/24/2025	5:45:00 PM	0.34
4/24/2025	6:00:00 PM	0.34
4/24/2025	6:15:00 PM	0.34
4/24/2025	6:30:00 PM	0.34
4/24/2025	6:45:00 PM	0.34
4/24/2025	7:00:00 PM	0.34
4/24/2025	7:15:00 PM	0.34
4/24/2025	7:30:00 PM	0.34
4/24/2025	7:45:00 PM	0.34
4/24/2025	8:00:00 PM	0.34
4/24/2025	8:15:00 PM	0.34
4/24/2025	8:30:00 PM	0.34
4/24/2025	8:45:00 PM	0.34
4/24/2025	9:00:00 PM	0.34
4/24/2025	9:15:00 PM	0.34
4/24/2025	9:30:00 PM	0.34
4/24/2025	9:45:00 PM	0.34
4/24/2025	10:00:00 PM	0.34
4/24/2025	10:15:00 PM	0.34
4/24/2025	10:30:00 PM	0.34
4/24/2025	10:45:00 PM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
4/24/2025	11:00:00 PM	0.34
4/24/2025	11:15:00 PM	0.34
4/24/2025	11:30:00 PM	0.34
4/24/2025	11:45:00 PM	0.34
4/25/2025	12:00:00 AM	0.34
4/25/2025	12:15:00 AM	0.34
4/25/2025	12:30:00 AM	0.34
4/25/2025	12:45:00 AM	0.34
4/25/2025	1:00:00 AM	0.34
4/25/2025	1:15:00 AM	0.34
4/25/2025	1:30:00 AM	0.34
4/25/2025	1:45:00 AM	0.34
4/25/2025	2:00:00 AM	0.34
4/25/2025	2:15:00 AM	0.34
4/25/2025	2:30:00 AM	0.34
4/25/2025	2:45:00 AM	0.34
4/25/2025	3:00:00 AM	0.34
4/25/2025	3:15:00 AM	0.34
4/25/2025	3:30:00 AM	0.34
4/25/2025	3:45:00 AM	0.34
4/25/2025	4:00:00 AM	0.34
4/25/2025	4:15:00 AM	0.34
4/25/2025	4:30:00 AM	0.34
4/25/2025	4:45:00 AM	0.34
4/25/2025	5:00:00 AM	0.34
4/25/2025	5:15:00 AM	0.34
4/25/2025	5:30:00 AM	0.34
4/25/2025	5:45:00 AM	0.34
4/25/2025	6:00:00 AM	0.34
4/25/2025	6:15:00 AM	0.34
4/25/2025	6:30:00 AM	0.34
4/25/2025	6:45:00 AM	0.34
4/25/2025	7:00:00 AM	0.34
4/25/2025	7:15:00 AM	0.34
4/25/2025	7:30:00 AM	0.34
4/25/2025	7:45:00 AM	0.34
4/25/2025	8:00:00 AM	0.34
4/25/2025	8:15:00 AM	0.34
4/25/2025	8:30:00 AM	0.34
4/25/2025	8:45:00 AM	0.34
4/25/2025	9:00:00 AM	0.33
4/25/2025	9:15:00 AM	0.32
4/25/2025	9:30:00 AM	0.31
4/25/2025	9:45:00 AM	0.3
4/25/2025	10:00:00 AM	0.3
4/25/2025	10:15:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
4/25/2025	10:30:00 AM	0.28
4/25/2025	10:45:00 AM	0.27
4/25/2025	11:00:00 AM	0.27
4/25/2025	11:15:00 AM	0.26
4/25/2025	11:30:00 AM	0.26
4/25/2025	11:45:00 AM	0.25
4/25/2025	12:00:00 PM	0.25
4/25/2025	12:15:00 PM	0.24
4/25/2025	12:30:00 PM	0.24
4/25/2025	12:45:00 PM	0.24
4/25/2025	1:00:00 PM	0.23
4/25/2025	1:15:00 PM	0.23
4/25/2025	1:30:00 PM	0.23
4/25/2025	1:45:00 PM	0.22
4/25/2025	2:00:00 PM	0.22
4/25/2025	2:15:00 PM	0.22
4/25/2025	2:30:00 PM	0.21
4/25/2025	2:45:00 PM	0.21
4/25/2025	3:00:00 PM	0.21
4/25/2025	3:15:00 PM	0.21
4/25/2025	3:30:00 PM	0.2
4/25/2025	3:45:00 PM	0.2
4/25/2025	4:00:00 PM	0.2
4/25/2025	4:15:00 PM	0.2
4/25/2025	4:30:00 PM	0.2
4/25/2025	4:45:00 PM	0.19
4/25/2025	5:00:00 PM	0.19
4/25/2025	5:15:00 PM	0.19
4/25/2025	5:30:00 PM	0.19
4/25/2025	5:45:00 PM	0.19
4/25/2025	6:00:00 PM	0.19
4/25/2025	6:15:00 PM	0.19
4/25/2025	6:30:00 PM	0.18
4/25/2025	6:45:00 PM	0.18
4/25/2025	7:00:00 PM	0.18
4/25/2025	7:15:00 PM	0.18
4/25/2025	7:30:00 PM	0.18
4/25/2025	7:45:00 PM	0.18
4/25/2025	8:00:00 PM	0.18
4/25/2025	8:15:00 PM	0.18
4/25/2025	8:30:00 PM	0.18
4/25/2025	8:45:00 PM	0.18
4/25/2025	9:00:00 PM	0.18
4/25/2025	9:15:00 PM	0.18
4/25/2025	9:30:00 PM	0.17
4/25/2025	9:45:00 PM	0.17

Billy Lake Return Gage

DATE	TIME	GAGE
4/25/2025	10:00:00 PM	0.17
4/25/2025	10:15:00 PM	0.17
4/25/2025	10:30:00 PM	0.17
4/25/2025	10:45:00 PM	0.17
4/25/2025	11:00:00 PM	0.17
4/25/2025	11:15:00 PM	0.17
4/25/2025	11:30:00 PM	0.17
4/25/2025	11:45:00 PM	0.17
4/26/2025	12:00:00 AM	0.16
4/26/2025	12:15:00 AM	0.16
4/26/2025	12:30:00 AM	0.16
4/26/2025	12:45:00 AM	0.16
4/26/2025	1:00:00 AM	0.16
4/26/2025	1:15:00 AM	0.16
4/26/2025	1:30:00 AM	0.16
4/26/2025	1:45:00 AM	0.16
4/26/2025	2:00:00 AM	0.16
4/26/2025	2:15:00 AM	0.16
4/26/2025	2:30:00 AM	0.16
4/26/2025	2:45:00 AM	0.16
4/26/2025	3:00:00 AM	0.16
4/26/2025	3:15:00 AM	0.16
4/26/2025	3:30:00 AM	0.16
4/26/2025	3:45:00 AM	0.16
4/26/2025	4:00:00 AM	0.16
4/26/2025	4:15:00 AM	0.15
4/26/2025	4:30:00 AM	0.15
4/26/2025	4:45:00 AM	0.15
4/26/2025	5:00:00 AM	0.15
4/26/2025	5:15:00 AM	0.15
4/26/2025	5:30:00 AM	0.15
4/26/2025	5:45:00 AM	0.15
4/26/2025	6:00:00 AM	0.15
4/26/2025	6:15:00 AM	0.15
4/26/2025	6:30:00 AM	0.15
4/26/2025	6:45:00 AM	0.15
4/26/2025	7:00:00 AM	0.15
4/26/2025	7:15:00 AM	0.15
4/26/2025	7:30:00 AM	0.15
4/26/2025	7:45:00 AM	0.15
4/26/2025	8:00:00 AM	0.17
4/26/2025	8:15:00 AM	0.18
4/26/2025	8:30:00 AM	0.18
4/26/2025	8:45:00 AM	0.19
4/26/2025	9:00:00 AM	0.2
4/26/2025	9:15:00 AM	0.21

Billy Lake Return Gage

DATE	TIME	GAGE
4/26/2025	9:30:00 AM	0.22
4/26/2025	9:45:00 AM	0.23
4/26/2025	10:00:00 AM	0.23
4/26/2025	10:15:00 AM	0.24
4/26/2025	10:30:00 AM	0.25
4/26/2025	10:45:00 AM	0.26
4/26/2025	11:00:00 AM	0.26
4/26/2025	11:15:00 AM	0.27
4/26/2025	11:30:00 AM	0.28
4/26/2025	11:45:00 AM	0.28
4/26/2025	12:00:00 PM	0.29
4/26/2025	12:15:00 PM	0.3
4/26/2025	12:30:00 PM	0.3
4/26/2025	12:45:00 PM	0.31
4/26/2025	1:00:00 PM	0.31
4/26/2025	1:15:00 PM	0.32
4/26/2025	1:30:00 PM	0.32
4/26/2025	1:45:00 PM	0.32
4/26/2025	2:00:00 PM	0.33
4/26/2025	2:15:00 PM	0.29
4/26/2025	2:30:00 PM	0.28
4/26/2025	2:45:00 PM	0.29
4/26/2025	3:00:00 PM	0.29
4/26/2025	3:15:00 PM	0.29
4/26/2025	3:30:00 PM	0.3
4/26/2025	3:45:00 PM	0.3
4/26/2025	4:00:00 PM	0.3
4/26/2025	4:15:00 PM	0.3
4/26/2025	4:30:00 PM	0.31
4/26/2025	4:45:00 PM	0.31
4/26/2025	5:00:00 PM	0.31
4/26/2025	5:15:00 PM	0.31
4/26/2025	5:30:00 PM	0.32
4/26/2025	5:45:00 PM	0.32
4/26/2025	6:00:00 PM	0.32
4/26/2025	6:15:00 PM	0.32
4/26/2025	6:30:00 PM	0.32
4/26/2025	6:45:00 PM	0.32
4/26/2025	7:00:00 PM	0.32
4/26/2025	7:15:00 PM	0.33
4/26/2025	7:30:00 PM	0.33
4/26/2025	7:45:00 PM	0.33
4/26/2025	8:00:00 PM	0.33
4/26/2025	8:15:00 PM	0.33
4/26/2025	8:30:00 PM	0.33
4/26/2025	8:45:00 PM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
4/26/2025	9:00:00 PM	0.33
4/26/2025	9:15:00 PM	0.33
4/26/2025	9:30:00 PM	0.33
4/26/2025	9:45:00 PM	0.33
4/26/2025	10:00:00 PM	0.34
4/26/2025	10:15:00 PM	0.34
4/26/2025	10:30:00 PM	0.34
4/26/2025	10:45:00 PM	0.34
4/26/2025	11:00:00 PM	0.34
4/26/2025	11:15:00 PM	0.34
4/26/2025	11:30:00 PM	0.34
4/26/2025	11:45:00 PM	0.34
4/27/2025	12:00:00 AM	0.34
4/27/2025	12:15:00 AM	0.34
4/27/2025	12:30:00 AM	0.34
4/27/2025	12:45:00 AM	0.34
4/27/2025	1:00:00 AM	0.34
4/27/2025	1:15:00 AM	0.34
4/27/2025	1:30:00 AM	0.34
4/27/2025	1:45:00 AM	0.34
4/27/2025	2:00:00 AM	0.35
4/27/2025	2:15:00 AM	0.35
4/27/2025	2:30:00 AM	0.35
4/27/2025	2:45:00 AM	0.35
4/27/2025	3:00:00 AM	0.35
4/27/2025	3:15:00 AM	0.35
4/27/2025	3:30:00 AM	0.35
4/27/2025	3:45:00 AM	0.35
4/27/2025	4:00:00 AM	0.35
4/27/2025	4:15:00 AM	0.35
4/27/2025	4:30:00 AM	0.35
4/27/2025	4:45:00 AM	0.35
4/27/2025	5:00:00 AM	0.35
4/27/2025	5:15:00 AM	0.35
4/27/2025	5:30:00 AM	0.35
4/27/2025	5:45:00 AM	0.35
4/27/2025	6:00:00 AM	0.35
4/27/2025	6:15:00 AM	0.35
4/27/2025	6:30:00 AM	0.35
4/27/2025	6:45:00 AM	0.35
4/27/2025	7:00:00 AM	0.35
4/27/2025	7:15:00 AM	0.35
4/27/2025	7:30:00 AM	0.35
4/27/2025	7:45:00 AM	0.35
4/27/2025	8:00:00 AM	0.35
4/27/2025	8:15:00 AM	0.35

Billy Lake Return Gage

DATE	TIME	GAGE
4/27/2025	8:30:00 AM	0.35
4/27/2025	8:45:00 AM	0.35
4/27/2025	9:00:00 AM	0.35
4/27/2025	9:15:00 AM	0.35
4/27/2025	9:30:00 AM	0.35
4/27/2025	9:45:00 AM	0.35
4/27/2025	10:00:00 AM	0.35
4/27/2025	10:15:00 AM	0.35
4/27/2025	10:30:00 AM	0.35
4/27/2025	10:45:00 AM	0.35
4/27/2025	11:00:00 AM	0.35
4/27/2025	11:15:00 AM	0.35
4/27/2025	11:30:00 AM	0.35
4/27/2025	11:45:00 AM	0.35
4/27/2025	12:00:00 PM	0.35
4/27/2025	12:15:00 PM	0.35
4/27/2025	12:30:00 PM	0.35
4/27/2025	12:45:00 PM	0.35
4/27/2025	1:00:00 PM	0.35
4/27/2025	1:15:00 PM	0.36
4/27/2025	1:30:00 PM	0.36
4/27/2025	1:45:00 PM	0.36
4/27/2025	2:00:00 PM	0.36
4/27/2025	2:15:00 PM	0.36
4/27/2025	2:30:00 PM	0.36
4/27/2025	2:45:00 PM	0.36
4/27/2025	3:00:00 PM	0.36
4/27/2025	3:15:00 PM	0.36
4/27/2025	3:30:00 PM	0.36
4/27/2025	3:45:00 PM	0.36
4/27/2025	4:00:00 PM	0.36
4/27/2025	4:15:00 PM	0.36
4/27/2025	4:30:00 PM	0.36
4/27/2025	4:45:00 PM	0.36
4/27/2025	5:00:00 PM	0.36
4/27/2025	5:15:00 PM	0.36
4/27/2025	5:30:00 PM	0.36
4/27/2025	5:45:00 PM	0.36
4/27/2025	6:00:00 PM	0.36
4/27/2025	6:15:00 PM	0.36
4/27/2025	6:30:00 PM	0.36
4/27/2025	6:45:00 PM	0.36
4/27/2025	7:00:00 PM	0.36
4/27/2025	7:15:00 PM	0.36
4/27/2025	7:30:00 PM	0.36
4/27/2025	7:45:00 PM	0.36

Billy Lake Return Gage

DATE	TIME	GAGE
4/27/2025	8:00:00 PM	0.36
4/27/2025	8:15:00 PM	0.36
4/27/2025	8:30:00 PM	0.36
4/27/2025	8:45:00 PM	0.36
4/27/2025	9:00:00 PM	0.36
4/27/2025	9:15:00 PM	0.36
4/27/2025	9:30:00 PM	0.36
4/27/2025	9:45:00 PM	0.36
4/27/2025	10:00:00 PM	0.36
4/27/2025	10:15:00 PM	0.36
4/27/2025	10:30:00 PM	0.36
4/27/2025	10:45:00 PM	0.36
4/27/2025	11:00:00 PM	0.36
4/27/2025	11:15:00 PM	0.36
4/27/2025	11:30:00 PM	0.36
4/27/2025	11:45:00 PM	0.36
4/28/2025	12:00:00 AM	0.36
4/28/2025	12:15:00 AM	0.36
4/28/2025	12:30:00 AM	0.36
4/28/2025	12:45:00 AM	0.36
4/28/2025	1:00:00 AM	0.36
4/28/2025	1:15:00 AM	0.36
4/28/2025	1:30:00 AM	0.36
4/28/2025	1:45:00 AM	0.37
4/28/2025	2:00:00 AM	0.36
4/28/2025	2:15:00 AM	0.36
4/28/2025	2:30:00 AM	0.36
4/28/2025	2:45:00 AM	0.36
4/28/2025	3:00:00 AM	0.36
4/28/2025	3:15:00 AM	0.36
4/28/2025	3:30:00 AM	0.36
4/28/2025	3:45:00 AM	0.36
4/28/2025	4:00:00 AM	0.36
4/28/2025	4:15:00 AM	0.36
4/28/2025	4:30:00 AM	0.36
4/28/2025	4:45:00 AM	0.36
4/28/2025	5:00:00 AM	0.36
4/28/2025	5:15:00 AM	0.36
4/28/2025	5:30:00 AM	0.36
4/28/2025	5:45:00 AM	0.36
4/28/2025	6:00:00 AM	0.36
4/28/2025	6:15:00 AM	0.36
4/28/2025	6:30:00 AM	0.36
4/28/2025	6:45:00 AM	0.36
4/28/2025	7:00:00 AM	0.36
4/28/2025	7:15:00 AM	0.36

Billy Lake Return Gage

DATE	TIME	GAGE
4/28/2025	7:30:00 AM	0.36
4/28/2025	7:45:00 AM	0.36
4/28/2025	8:00:00 AM	0.36
4/28/2025	8:15:00 AM	0.36
4/28/2025	8:30:00 AM	0.36
4/28/2025	8:45:00 AM	0.36
4/28/2025	9:00:00 AM	0.36
4/28/2025	9:15:00 AM	0.36
4/28/2025	9:30:00 AM	0.36
4/28/2025	9:45:00 AM	0.36
4/28/2025	10:00:00 AM	0.36
4/28/2025	10:15:00 AM	0.36
4/28/2025	10:30:00 AM	0.36
4/28/2025	10:45:00 AM	0.36
4/28/2025	11:00:00 AM	0.36
4/28/2025	11:15:00 AM	0.36
4/28/2025	11:30:00 AM	0.36
4/28/2025	11:45:00 AM	0.36
4/28/2025	12:00:00 PM	0.36
4/28/2025	12:15:00 PM	0.36
4/28/2025	12:30:00 PM	0.36
4/28/2025	12:45:00 PM	0.36
4/28/2025	1:00:00 PM	0.36
4/28/2025	1:15:00 PM	0.36
4/28/2025	1:30:00 PM	0.36
4/28/2025	1:45:00 PM	0.36
4/28/2025	2:00:00 PM	0.36
4/28/2025	2:15:00 PM	0.36
4/28/2025	2:30:00 PM	0.36
4/28/2025	2:45:00 PM	0.36
4/28/2025	3:00:00 PM	0.36
4/28/2025	3:15:00 PM	0.36
4/28/2025	3:30:00 PM	0.36
4/28/2025	3:45:00 PM	0.36
4/28/2025	4:00:00 PM	0.36
4/28/2025	4:15:00 PM	0.36
4/28/2025	4:30:00 PM	0.36
4/28/2025	4:45:00 PM	0.36
4/28/2025	5:00:00 PM	0.36
4/28/2025	5:15:00 PM	0.36
4/28/2025	5:30:00 PM	0.36
4/28/2025	5:45:00 PM	0.36
4/28/2025	6:00:00 PM	0.36
4/28/2025	6:15:00 PM	0.36
4/28/2025	6:30:00 PM	0.36
4/28/2025	6:45:00 PM	0.36

Billy Lake Return Gage

DATE	TIME	GAGE
4/28/2025	7:00:00 PM	0.36
4/28/2025	7:15:00 PM	0.36
4/28/2025	7:30:00 PM	0.36
4/28/2025	7:45:00 PM	0.36
4/28/2025	8:00:00 PM	0.36
4/28/2025	8:15:00 PM	0.36
4/28/2025	8:30:00 PM	0.36
4/28/2025	8:45:00 PM	0.36
4/28/2025	9:00:00 PM	0.36
4/28/2025	9:15:00 PM	0.35
4/28/2025	9:30:00 PM	0.35
4/28/2025	9:45:00 PM	0.35
4/28/2025	10:00:00 PM	0.35
4/28/2025	10:15:00 PM	0.35
4/28/2025	10:30:00 PM	0.35
4/28/2025	10:45:00 PM	0.35
4/28/2025	11:00:00 PM	0.35
4/28/2025	11:15:00 PM	0.35
4/28/2025	11:30:00 PM	0.35
4/28/2025	11:45:00 PM	0.35
4/29/2025	12:00:00 AM	0.35
4/29/2025	12:15:00 AM	0.35
4/29/2025	12:30:00 AM	0.35
4/29/2025	12:45:00 AM	0.35
4/29/2025	1:00:00 AM	0.35
4/29/2025	1:15:00 AM	0.35
4/29/2025	1:30:00 AM	0.35
4/29/2025	1:45:00 AM	0.35
4/29/2025	2:00:00 AM	0.35
4/29/2025	2:15:00 AM	0.35
4/29/2025	2:30:00 AM	0.35
4/29/2025	2:45:00 AM	0.35
4/29/2025	3:00:00 AM	0.35
4/29/2025	3:15:00 AM	0.35
4/29/2025	3:30:00 AM	0.35
4/29/2025	3:45:00 AM	0.35
4/29/2025	4:00:00 AM	0.35
4/29/2025	4:15:00 AM	0.35
4/29/2025	4:30:00 AM	0.35
4/29/2025	4:45:00 AM	0.35
4/29/2025	5:00:00 AM	0.35
4/29/2025	5:15:00 AM	0.35
4/29/2025	5:30:00 AM	0.35
4/29/2025	5:45:00 AM	0.35
4/29/2025	6:00:00 AM	0.35
4/29/2025	6:15:00 AM	0.35

Billy Lake Return Gage

DATE	TIME	GAGE
4/29/2025	6:30:00 AM	0.35
4/29/2025	6:45:00 AM	0.35
4/29/2025	7:00:00 AM	0.35
4/29/2025	7:15:00 AM	0.35
4/29/2025	7:30:00 AM	0.35
4/29/2025	7:45:00 AM	0.35
4/29/2025	8:00:00 AM	0.35
4/29/2025	8:15:00 AM	0.35
4/29/2025	8:30:00 AM	0.35
4/29/2025	8:45:00 AM	0.35
4/29/2025	9:00:00 AM	0.35
4/29/2025	9:15:00 AM	0.35
4/29/2025	9:30:00 AM	0.35
4/29/2025	9:45:00 AM	0.35
4/29/2025	10:00:00 AM	0.35
4/29/2025	10:15:00 AM	0.35
4/29/2025	10:30:00 AM	0.35
4/29/2025	10:45:00 AM	0.35
4/29/2025	11:00:00 AM	0.35
4/29/2025	11:15:00 AM	0.35
4/29/2025	11:30:00 AM	0.35
4/29/2025	11:45:00 AM	0.35
4/29/2025	12:00:00 PM	0.35
4/29/2025	12:15:00 PM	0.35
4/29/2025	12:30:00 PM	0.35
4/29/2025	12:45:00 PM	0.35
4/29/2025	1:00:00 PM	0.35
4/29/2025	1:15:00 PM	0.35
4/29/2025	1:30:00 PM	0.35
4/29/2025	1:45:00 PM	0.35
4/29/2025	2:00:00 PM	0.35
4/29/2025	2:15:00 PM	0.35
4/29/2025	2:30:00 PM	0.35
4/29/2025	2:45:00 PM	0.35
4/29/2025	3:00:00 PM	0.35
4/29/2025	3:15:00 PM	0.35
4/29/2025	3:30:00 PM	0.35
4/29/2025	3:45:00 PM	0.35
4/29/2025	4:00:00 PM	0.35
4/29/2025	4:15:00 PM	0.35
4/29/2025	4:30:00 PM	0.35
4/29/2025	4:45:00 PM	0.35
4/29/2025	5:00:00 PM	0.35
4/29/2025	5:15:00 PM	0.35
4/29/2025	5:30:00 PM	0.35
4/29/2025	5:45:00 PM	0.35

Billy Lake Return Gage

DATE	TIME	GAGE
4/29/2025	6:00:00 PM	0.35
4/29/2025	6:15:00 PM	0.35
4/29/2025	6:30:00 PM	0.35
4/29/2025	6:45:00 PM	0.34
4/29/2025	7:00:00 PM	0.35
4/29/2025	7:15:00 PM	0.34
4/29/2025	7:30:00 PM	0.34
4/29/2025	7:45:00 PM	0.34
4/29/2025	8:00:00 PM	0.34
4/29/2025	8:15:00 PM	0.34
4/29/2025	8:30:00 PM	0.34
4/29/2025	8:45:00 PM	0.34
4/29/2025	9:00:00 PM	0.34
4/29/2025	9:15:00 PM	0.34
4/29/2025	9:30:00 PM	0.34
4/29/2025	9:45:00 PM	0.34
4/29/2025	10:00:00 PM	0.34
4/29/2025	10:15:00 PM	0.34
4/29/2025	10:30:00 PM	0.34
4/29/2025	10:45:00 PM	0.34
4/29/2025	11:00:00 PM	0.34
4/29/2025	11:15:00 PM	0.34
4/29/2025	11:30:00 PM	0.34
4/29/2025	11:45:00 PM	0.34
4/30/2025	12:00:00 AM	0.34
4/30/2025	12:15:00 AM	0.34
4/30/2025	12:30:00 AM	0.34
4/30/2025	12:45:00 AM	0.34
4/30/2025	1:00:00 AM	0.34
4/30/2025	1:15:00 AM	0.34
4/30/2025	1:30:00 AM	0.34
4/30/2025	1:45:00 AM	0.34
4/30/2025	2:00:00 AM	0.34
4/30/2025	2:15:00 AM	0.34
4/30/2025	2:30:00 AM	0.34
4/30/2025	2:45:00 AM	0.34
4/30/2025	3:00:00 AM	0.34
4/30/2025	3:15:00 AM	0.34
4/30/2025	3:30:00 AM	0.34
4/30/2025	3:45:00 AM	0.34
4/30/2025	4:00:00 AM	0.34
4/30/2025	4:15:00 AM	0.34
4/30/2025	4:30:00 AM	0.34
4/30/2025	4:45:00 AM	0.34
4/30/2025	5:00:00 AM	0.34
4/30/2025	5:15:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
4/30/2025	5:30:00 AM	0.34
4/30/2025	5:45:00 AM	0.34
4/30/2025	6:00:00 AM	0.34
4/30/2025	6:15:00 AM	0.34
4/30/2025	6:30:00 AM	0.34
4/30/2025	6:45:00 AM	0.34
4/30/2025	7:00:00 AM	0.34
4/30/2025	7:15:00 AM	0.34
4/30/2025	7:30:00 AM	0.34
4/30/2025	7:45:00 AM	0.34
4/30/2025	8:00:00 AM	0.34
4/30/2025	8:15:00 AM	0.34
4/30/2025	8:30:00 AM	0.34
4/30/2025	8:45:00 AM	0.34
4/30/2025	9:00:00 AM	0.34
4/30/2025	9:15:00 AM	0.34
4/30/2025	9:30:00 AM	0.34
4/30/2025	9:45:00 AM	0.34
4/30/2025	10:00:00 AM	0.34
4/30/2025	10:15:00 AM	0.34
4/30/2025	10:30:00 AM	0.34
4/30/2025	10:45:00 AM	0.34
4/30/2025	11:00:00 AM	0.34
4/30/2025	11:15:00 AM	0.34
4/30/2025	11:30:00 AM	0.34
4/30/2025	11:45:00 AM	0.34
4/30/2025	12:00:00 PM	0.34
4/30/2025	12:15:00 PM	0.34
4/30/2025	12:30:00 PM	0.34
4/30/2025	12:45:00 PM	0.34
4/30/2025	1:00:00 PM	0.34
4/30/2025	1:15:00 PM	0.34
4/30/2025	1:30:00 PM	0.34
4/30/2025	1:45:00 PM	0.34
4/30/2025	2:00:00 PM	0.34
4/30/2025	2:15:00 PM	0.34
4/30/2025	2:30:00 PM	0.34
4/30/2025	2:45:00 PM	0.34
4/30/2025	3:00:00 PM	0.33
4/30/2025	3:15:00 PM	0.33
4/30/2025	3:30:00 PM	0.33
4/30/2025	3:45:00 PM	0.33
4/30/2025	4:00:00 PM	0.33
4/30/2025	4:15:00 PM	0.33
4/30/2025	4:30:00 PM	0.33
4/30/2025	4:45:00 PM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
4/30/2025	5:00:00 PM	0.33
4/30/2025	5:15:00 PM	0.33
4/30/2025	5:30:00 PM	0.33
4/30/2025	5:45:00 PM	0.33
4/30/2025	6:00:00 PM	0.33
4/30/2025	6:15:00 PM	0.33
4/30/2025	6:30:00 PM	0.33
4/30/2025	6:45:00 PM	0.32
4/30/2025	7:00:00 PM	0.32
4/30/2025	7:15:00 PM	0.32
4/30/2025	7:30:00 PM	0.32
4/30/2025	7:45:00 PM	0.32
4/30/2025	8:00:00 PM	0.32
4/30/2025	8:15:00 PM	0.32
4/30/2025	8:30:00 PM	0.32
4/30/2025	8:45:00 PM	0.32
4/30/2025	9:00:00 PM	0.31
4/30/2025	9:15:00 PM	0.31
4/30/2025	9:30:00 PM	0.31
4/30/2025	9:45:00 PM	0.31
4/30/2025	10:00:00 PM	0.31
4/30/2025	10:15:00 PM	0.31
4/30/2025	10:30:00 PM	0.31
4/30/2025	10:45:00 PM	0.31
4/30/2025	11:00:00 PM	0.31
4/30/2025	11:15:00 PM	0.31
4/30/2025	11:30:00 PM	0.31
4/30/2025	11:45:00 PM	0.31

Party: BLP / BJA	Width: 20.8 ft	Processed by: BJA
Boat/Motor: BOAT	Area: 66.6 ft ²	Mean Velocity: 0.836 ft/s
Gage Height: 3.47 ft	G.H.Change: 0.000 ft	Discharge: 55.6 ft ³ /s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.00°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft ²	Diff.: 0.000%
Depth: Composite (BT)	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:		ADCP:	
BT 3-Beam Solution: YES	Max. Vel.: 1.45 ft/s	Type/Freq.: StreamPro / 2000 kHz	
WT 3-Beam Solution: YES	Max. Depth: 3.58 ft	Serial #: 2370	Firmware: 31.17
BT Error Vel.: 0.33 ft/s	Mean Depth: 3.19 ft	Bin Size: 17 cm	Blank: 3 cm
WT Error Vel.: 0.98 ft/s	% Meas.: 54.83	BT Mode: 10	BT Pings: 2
BT Up Vel.: 1.00 ft/s	Water Temp.: None	WT Mode: 12	WT Pings: 6
WT Up Vel.: 1.64 ft/s	ADCP Temp.: 72.2 °F		
Use Weighted Mean Depth: YES			

Performed Diag. Test: YES
 Performed Moving Bed Test: NO
 Performed Compass Calibration: NO Evaluation: NO
 Meas. Location: BRIDGE

Project Name: 250415 LOR @ MAZOURKA_0
 Software: 2.26.00.04

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	L	2	2	29	11.3	30.4	10.2	2.30	2.22	56.5	21	67	11:50	11:50	0.52	0.85	0	0
001	R	2	2	34	10.9	29.9	8.97	2.22	2.12	54.1	21	67	11:51	11:51	0.46	0.80	0	0
002	L	2	2	39	11.3	30.1	10.5	2.05	2.01	55.9	21	67	11:51	11:52	0.42	0.84	0	0
003	R	2	2	28	11.3	31.6	8.83	2.15	2.08	55.9	20	65	11:52	11:53	0.56	0.86	0	0
Mean		2	2	32	11.2	30.5	9.61	2.18	2.11	55.6	21	67	Total	00:03	0.49	0.84	0	0
SDev		0	0	5	0.203	0.744	0.834	0.105	0.088	1.01	0.3	0.9			0.06	0.02		
SD/M		0.0%	0.0%	15.9%	1.8%	2.4%	8.7%	4.8%	4.2%	1.8%	1.4%	1.4%			13.2%	2.7%		

Remarks:

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	1	0	3	9	0.748	-0.039	2.894	0.016	0.016	0	55	56.3	67.1	156	159	0	28	28
2025	4	1	0	13	9	0.741	-0.052	2.894	0.016	0.016	0	55.5	56.3	67.9	156	159	0	27	28
2025	4	1	0	23	9	0.728	-0.026	2.894	0.016	0.013	0	55.5	56.3	61.1	156	159	0	27	28
2025	4	1	0	33	9	0.768	-0.043	2.894	0.02	0.016	0	55.5	56.8	64.5	156	160	0	27	28
2025	4	1	0	43	9	0.709	-0.069	2.894	0.016	0.013	0	55	55.9	63.6	156	159	0	28	29
2025	4	1	0	53	9	0.748	-0.092	2.894	0.016	0.016	0	54.6	55.9	67.1	154	158	0	27	28
2025	4	1	1	3	9	0.705	-0.049	2.894	0.016	0.016	0	55.5	56.8	50.7	156	160	0	27	28
2025	4	1	1	13	9	0.712	-0.052	2.894	0.016	0.013	0	55	55.9	67.5	155	158	0	27	28
2025	4	1	1	23	9	0.755	-0.066	2.894	0.016	0.016	0	54.2	55.9	67.9	154	158	0	28	28
2025	4	1	1	33	9	0.692	-0.036	2.894	0.016	0.016	0	55	55.9	68.4	155	158	0	27	28
2025	4	1	1	43	9	0.732	-0.056	2.894	0.016	0.016	0	54.6	56.3	67.1	155	159	0	28	28
2025	4	1	1	53	9	0.715	-0.075	2.894	0.016	0.016	0	55.5	56.3	67.1	156	159	0	27	28
2025	4	1	2	3	9	0.751	-0.069	2.894	0.016	0.013	0	55	55.9	67.9	156	159	0	28	29
2025	4	1	2	13	9	0.768	-0.039	2.894	0.016	0.013	0	54.6	56.3	67.9	155	159	0	28	28
2025	4	1	2	23	9	0.761	-0.062	2.894	0.016	0.013	0	55.5	56.3	67.5	156	159	0	27	28
2025	4	1	2	33	9	0.686	-0.059	2.894	0.016	0.013	0	55	56.8	67.9	156	160	0	28	28
2025	4	1	2	43	9	0.719	-0.046	2.894	0.016	0.016	0	55	56.3	67.5	156	159	0	28	28
2025	4	1	2	53	9	0.689	-0.056	2.894	0.02	0.016	0	55	56.3	67.9	155	159	0	27	28
2025	4	1	3	3	9	0.728	-0.052	2.894	0.016	0.016	0	54.6	55.5	67.5	155	158	0	28	29
2025	4	1	3	13	9	0.741	-0.043	2.89	0.016	0.013	0	54.6	55.9	67.1	155	158	0	28	28
2025	4	1	3	23	9	0.745	-0.079	2.894	0.016	0.013	0	54.6	55.9	67.5	155	158	0	28	28
2025	4	1	3	33	9	0.728	-0.079	2.894	0.016	0.013	0	54.6	55.9	67.1	154	158	0	27	28
2025	4	1	3	43	9	0.741	-0.072	2.894	0.016	0.013	0	54.6	55.9	67.1	154	158	0	27	28
2025	4	1	3	53	9	0.722	-0.062	2.894	0.016	0.016	0	54.2	55.9	66.7	154	158	0	28	28
2025	4	1	4	3	9	0.728	-0.069	2.894	0.016	0.013	0	54.2	55.5	65.4	154	158	0	28	29
2025	4	1	4	13	9	0.738	-0.026	2.894	0.016	0.016	0	54.6	56.3	66.7	155	159	0	28	28
2025	4	1	4	23	9	0.774	-0.066	2.89	0.016	0.013	0	54.2	55.5	52	154	158	0	28	29
2025	4	1	4	33	9	0.722	-0.072	2.894	0.016	0.013	0	54.6	56.3	66.2	155	159	0	28	28
2025	4	1	4	43	9	0.702	-0.102	2.89	0.016	0.016	0	54.6	55.9	66.2	155	158	0	28	28
2025	4	1	4	53	9	0.748	-0.052	2.894	0.016	0.013	0	54.6	55.9	65.8	155	158	0	28	28
2025	4	1	5	3	9	0.745	-0.072	2.894	0.016	0.016	0	54.6	56.3	65.8	155	159	0	28	28
2025	4	1	5	13	9	0.755	-0.043	2.894	0.016	0.013	0	54.2	55.5	52.5	154	158	0	28	29
2025	4	1	5	23	9	0.751	-0.066	2.894	0.016	0.013	0	54.6	55.9	64.5	155	158	0	28	28
2025	4	1	5	33	9	0.699	-0.023	2.894	0.016	0.013	0	55	55.9	65.4	156	159	0	28	29
2025	4	1	5	43	9	0.761	-0.039	2.89	0.016	0.013	0	54.6	56.3	65.4	155	159	0	28	28
2025	4	1	5	53	9	0.705	-0.079	2.894	0.016	0.016	0	54.6	55.9	61.1	154	158	0	27	28
2025	4	1	6	3	9	0.709	-0.056	2.894	0.016	0.013	0	54.6	55.9	63.2	154	158	0	27	28
2025	4	1	6	13	9	0.764	-0.062	2.897	0.013	0.01	0	53.8	55.5	57.6	153	157	0	28	28
2025	4	1	6	23	9	0.728	-0.072	2.897	0.013	0.01	0	54.2	55.5	64.9	154	158	0	28	29
2025	4	1	6	33	9	0.755	-0.049	2.897	0.016	0.013	0	54.2	55.9	59.3	154	158	0	28	28
2025	4	1	6	43	9	0.774	-0.072	2.9	0.016	0.013	0	54.2	55.5	61.1	154	158	0	28	29
2025	4	1	6	53	9	0.709	-0.013	2.897	0.016	0.013	0	54.6	55.9	46.9	155	158	0	28	28
2025	4	1	7	3	9	0.725	-0.085	2.897	0.013	0.01	0	55	55.9	49.5	156	158	0	28	28
2025	4	1	7	13	9	0.764	-0.072	2.9	0.016	0.013	0	55	55.5	64.5	155	157	0	27	28
2025	4	1	7	23	9	0.725	-0.085	2.897	0.016	0.016	0	54.6	55.5	46.9	155	158	0	28	29
2025	4	1	7	33	9	0.732	-0.052	2.897	0.016	0.013	0	54.6	55.9	53.8	154	158	0	27	28
2025	4	1	7	43	9	0.738	-0.075	2.897	0.016	0.016	0	54.2	55.5	54.2	154	157	0	28	28
2025	4	1	7	53	9	0.745	-0.049	2.897	0.013	0.01	0	54.2	55.5	55.9	154	157	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	1	8	3	9	0.732	-0.043	2.897	0.016	0.013	0	54.6	55	55.9	155	157	0	28	29
2025	4	1	8	13	9	0.771	-0.059	2.897	0.016	0.013	0	54.2	55	65.4	154	157	0	28	29
2025	4	1	8	23	9	0.741	-0.043	2.894	0.016	0.013	0	54.2	55	65.8	154	157	0	28	29
2025	4	1	8	33	9	0.771	-0.098	2.894	0.016	0.013	0	53.8	54.6	66.2	153	156	0	28	29
2025	4	1	8	43	9	0.728	-0.049	2.894	0.013	0.01	0	54.6	55.5	65.8	155	158	0	28	29
2025	4	1	8	53	9	0.715	-0.043	2.894	0.016	0.016	0	54.2	55.5	65.4	154	157	0	28	28
2025	4	1	9	3	9	0.741	-0.072	2.894	0.02	0.016	0	54.2	55.5	65.8	154	157	0	28	28
2025	4	1	9	13	9	0.738	-0.052	2.894	0.016	0.016	0	54.2	55	58	154	157	0	28	29
2025	4	1	9	23	9	0.738	-0.079	2.89	0.016	0.016	0	54.2	55	67.1	154	157	0	28	29
2025	4	1	9	33	9	0.728	-0.069	2.894	0.016	0.016	0	53.8	55	56.8	153	156	0	28	28
2025	4	1	9	43	9	0.732	-0.089	2.894	0.016	0.013	0	54.2	55	66.2	153	156	0	27	28
2025	4	1	9	53	9	0.725	-0.072	2.894	0.016	0.013	0	54.2	55	65.8	153	156	0	27	28
2025	4	1	10	3	9	0.738	-0.056	2.894	0.016	0.013	0	53.8	54.6	67.1	153	156	0	28	29
2025	4	1	10	13	9	0.709	-0.066	2.894	0.013	0.01	0	53.3	54.6	67.5	152	156	0	28	29
2025	4	1	10	23	9	0.768	-0.092	2.894	0.016	0.016	0	53.3	54.2	61.5	152	155	0	28	29
2025	4	1	10	33	9	0.725	-0.072	2.894	0.013	0.01	0	53.3	54.6	54.6	152	155	0	28	28
2025	4	1	10	43	9	0.771	-0.062	2.894	0.016	0.013	0	53.3	55	55	152	156	0	28	28
2025	4	1	10	53	9	0.748	-0.056	2.894	0.013	0.01	0	53.8	55	47.3	153	157	0	28	29
2025	4	1	11	3	9	0.725	-0.056	2.894	0.016	0.013	0	54.2	55.5	53.8	154	157	0	28	28
2025	4	1	11	13	9	0.751	-0.056	2.894	0.016	0.013	0	54.2	55.5	53.3	154	157	0	28	28
2025	4	1	11	23	9	0.771	-0.043	2.894	0.016	0.016	0	54.2	55.5	54.2	153	157	0	27	28
2025	4	1	11	33	9	0.722	-0.072	2.894	0.016	0.016	0	55	55.5	57.2	155	158	0	27	29
2025	4	1	11	43	9	0.702	-0.043	2.894	0.016	0.016	0	54.6	55.9	57.2	155	158	0	28	28
2025	4	1	11	53	9	0.712	-0.069	2.894	0.016	0.013	0	55	55.9	58.9	155	158	0	27	28
2025	4	1	12	3	9	0.732	-0.026	2.894	0.016	0.016	0	54.6	55.9	49.9	156	158	0	29	28
2025	4	1	12	13	9	0.735	-0.062	2.897	0.016	0.013	0	54.6	55.9	57.2	155	158	0	28	28
2025	4	1	12	23	9	0.705	-0.072	2.897	0.016	0.013	0	55	55.9	68.4	155	158	0	27	28
2025	4	1	12	33	9	0.768	-0.026	2.897	0.016	0.013	0	54.6	55.5	60.6	154	157	0	27	28
2025	4	1	12	43	9	0.761	-0.03	2.897	0.016	0.013	0	54.6	55.5	59.3	155	157	0	28	28
2025	4	1	12	53	9	0.768	-0.052	2.897	0.016	0.013	0	54.6	55.5	52.5	155	157	0	28	28
2025	4	1	13	3	9	0.732	-0.062	2.897	0.02	0.016	0	54.6	55.5	58	155	157	0	28	28
2025	4	1	13	13	9	0.764	-0.069	2.897	0.016	0.013	0	54.2	55.5	57.6	154	157	0	28	28
2025	4	1	13	23	9	0.728	-0.056	2.897	0.016	0.013	0	54.6	55.9	59.8	155	158	0	28	28
2025	4	1	13	33	9	0.699	-0.043	2.897	0.016	0.013	0	55	55.9	54.6	156	158	0	28	28
2025	4	1	13	43	9	0.738	-0.033	2.897	0.016	0.016	0	55	55.9	49	156	159	0	28	29
2025	4	1	13	53	9	0.774	-0.056	2.897	0.016	0.016	0	55	55.9	60.6	156	158	0	28	28
2025	4	1	14	3	9	0.741	-0.043	2.897	0.016	0.016	0	55.5	56.3	50.7	157	159	0	28	28
2025	4	1	14	13	9	0.741	-0.075	2.897	0.016	0.013	0	55	55.9	48.2	156	158	0	28	28
2025	4	1	14	23	9	0.712	-0.039	2.9	0.013	0.01	0	55.5	56.8	67.1	157	160	0	28	28
2025	4	1	14	33	9	0.764	-0.043	2.9	0.02	0.016	0	55.9	57.2	46	157	160	0	27	27
2025	4	1	14	43	9	0.745	-0.039	2.9	0.02	0.016	0	55	55.9	66.2	156	158	0	28	28
2025	4	1	14	53	9	0.732	-0.075	2.9	0.016	0.013	0	55	56.3	46.4	156	159	0	28	28
2025	4	1	15	3	9	0.709	-0.052	2.9	0.016	0.016	0	55.9	56.3	49.9	157	159	0	27	28
2025	4	1	15	13	9	0.715	-0.036	2.9	0.016	0.016	0	55	56.3	54.6	156	159	0	28	28
2025	4	1	15	23	9	0.732	-0.036	2.9	0.016	0.013	0	55.5	56.3	64.9	156	159	0	27	28
2025	4	1	15	33	9	0.728	-0.046	2.9	0.016	0.013	0	55.9	56.8	50.3	158	160	0	28	28
2025	4	1	15	43	9	0.755	-0.075	2.904	0.016	0.016	0	55	56.3	69.2	156	159	0	28	28
2025	4	1	15	53	9	0.728	-0.056	2.9	0.016	0.013	0	55.9	56.3	61.9	157	160	0	27	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	1	16	3	9	0.732	-0.043	2.9	0.016	0.016	0	55	55.9	65.4	156	159	0	28	29
2025	4	1	16	13	9	0.725	-0.059	2.9	0.016	0.013	0	55	56.3	55.5	156	159	0	28	28
2025	4	1	16	23	9	0.732	-0.03	2.9	0.016	0.013	0	54.6	55.9	66.2	155	159	0	28	29
2025	4	1	16	33	9	0.725	-0.059	2.9	0.016	0.016	0	54.2	55.9	57.6	154	157	0	28	27
2025	4	1	16	43	9	0.741	-0.072	2.9	0.016	0.016	0	54.2	55.5	63.2	154	157	0	28	28
2025	4	1	16	53	9	0.758	-0.039	2.9	0.016	0.013	0	55.5	56.3	55.5	156	159	0	27	28
2025	4	1	17	3	9	0.712	-0.046	2.9	0.016	0.016	0	55	56.3	59.3	156	159	0	28	28
2025	4	1	17	13	9	0.732	-0.026	2.9	0.016	0.016	0	54.6	55.9	62.8	155	158	0	28	28
2025	4	1	17	23	9	0.705	-0.043	2.9	0.02	0.016	0	54.6	56.3	54.6	154	159	0	27	28
2025	4	1	17	33	9	0.768	-0.046	2.9	0.016	0.016	0	55	55.9	62.8	156	158	0	28	28
2025	4	1	17	43	9	0.725	-0.03	2.9	0.013	0.01	0	55.5	56.3	67.9	156	159	0	27	28
2025	4	1	17	53	9	0.699	-0.066	2.9	0.016	0.016	0	55.5	56.3	61.5	156	159	0	27	28
2025	4	1	18	3	9	0.787	-0.03	2.9	0.016	0.013	0	55	55.9	58.5	155	158	0	27	28
2025	4	1	18	13	9	0.738	-0.02	2.897	0.016	0.016	0	55.5	56.8	55.5	156	159	0	27	27
2025	4	1	18	23	9	0.751	-0.056	2.897	0.016	0.016	0	55.5	55.9	58.9	156	159	0	27	29
2025	4	1	18	33	9	0.761	-0.033	2.897	0.016	0.013	0	55.5	56.3	61.9	156	159	0	27	28
2025	4	1	18	43	9	0.764	-0.03	2.897	0.016	0.013	0	55.5	56.8	59.8	157	160	0	28	28
2025	4	1	18	53	9	0.725	-0.043	2.897	0.016	0.016	0	55.9	56.8	58	157	160	0	27	28
2025	4	1	19	3	9	0.745	-0.089	2.897	0.016	0.016	0	55	56.3	60.6	156	159	0	28	28
2025	4	1	19	13	9	0.712	-0.023	2.897	0.016	0.013	0	55	56.3	67.1	156	159	0	28	28
2025	4	1	19	23	9	0.735	-0.079	2.897	0.016	0.016	0	55.5	56.8	68.4	156	160	0	27	28
2025	4	1	19	33	9	0.741	-0.062	2.897	0.013	0.01	0	55	56.8	64.5	156	160	0	28	28
2025	4	1	19	43	9	0.679	-0.03	2.897	0.016	0.013	0	55	56.8	65.4	156	160	0	28	28
2025	4	1	19	53	9	0.794	-0.069	2.897	0.02	0.016	0	55.5	56.3	68.8	156	159	0	27	28
2025	4	1	20	3	9	0.751	-0.046	2.897	0.016	0.013	0	55.5	56.3	68.4	156	159	0	27	28
2025	4	1	20	13	9	0.712	-0.033	2.894	0.016	0.013	0	55.9	56.8	68.4	156	160	0	26	28
2025	4	1	20	23	9	0.732	-0.052	2.894	0.016	0.016	0	55.5	56.8	68.8	156	160	0	27	28
2025	4	1	20	33	9	0.741	-0.03	2.894	0.016	0.013	0	55.5	56.3	68.8	156	159	0	27	28
2025	4	1	20	43	9	0.722	-0.059	2.894	0.016	0.013	0	55	56.3	69.7	156	159	0	28	28
2025	4	1	20	53	9	0.712	-0.043	2.894	0.016	0.013	0	55.5	56.3	68.8	156	159	0	27	28
2025	4	1	21	3	9	0.741	-0.059	2.894	0.013	0.01	0	55	56.8	69.2	156	159	0	28	27
2025	4	1	21	13	9	0.715	-0.03	2.894	0.016	0.013	0	55	56.3	69.2	156	159	0	28	28
2025	4	1	21	23	9	0.728	-0.059	2.894	0.016	0.013	0	55.5	55.9	69.2	156	159	0	27	29
2025	4	1	21	33	9	0.758	-0.056	2.894	0.016	0.013	0	55	56.3	68.8	156	159	0	28	28
2025	4	1	21	43	9	0.751	-0.056	2.894	0.016	0.016	0	55	56.3	67.9	155	159	0	27	28
2025	4	1	21	53	9	0.722	-0.049	2.89	0.016	0.013	0	55	56.3	65.4	156	159	0	28	28
2025	4	1	22	3	9	0.758	-0.072	2.89	0.016	0.013	0	55	56.3	68.4	155	159	0	27	28
2025	4	1	22	13	9	0.728	-0.059	2.89	0.02	0.016	0	54.6	56.3	68.4	155	159	0	28	28
2025	4	1	22	23	9	0.735	-0.043	2.89	0.016	0.016	0	54.6	55.9	55.9	155	158	0	28	28
2025	4	1	22	33	9	0.735	-0.043	2.89	0.016	0.013	0	54.6	55.9	46.4	155	158	0	28	28
2025	4	1	22	43	9	0.725	-0.059	2.89	0.016	0.016	0	55	56.3	45.6	155	159	0	27	28
2025	4	1	22	53	9	0.722	-0.056	2.89	0.016	0.013	0	54.6	56.3	49	155	159	0	28	28
2025	4	1	23	3	9	0.755	-0.069	2.89	0.016	0.013	0	54.6	55.9	48.2	155	159	0	28	29
2025	4	1	23	13	9	0.738	-0.049	2.89	0.016	0.013	0	54.6	56.3	45.6	155	159	0	28	28
2025	4	1	23	23	9	0.781	-0.043	2.89	0.016	0.016	0	54.6	55.5	46	155	158	0	28	29
2025	4	1	23	33	9	0.722	-0.075	2.887	0.016	0.013	0	54.6	56.3	44.7	155	159	0	28	28
2025	4	1	23	43	9	0.751	-0.039	2.887	0.02	0.016	0	54.6	55.9	45.2	155	158	0	28	28
2025	4	1	23	53	9	0.699	-0.023	2.89	0.016	0.016	0	55	56.3	44.3	155	159	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	2	0	3	9	0.751	-0.056	2.89	0.016	0.013	0	54.6	55.9	44.3	154	158	0	27	28
2025	4	2	0	13	9	0.712	-0.052	2.89	0.016	0.013	0	54.2	55.9	44.3	154	158	0	28	28
2025	4	2	0	23	9	0.692	-0.039	2.887	0.013	0.01	0	54.6	56.3	43.9	155	159	0	28	28
2025	4	2	0	33	9	0.784	-0.056	2.887	0.016	0.016	0	54.2	56.3	46	154	159	0	28	28
2025	4	2	0	43	9	0.705	-0.072	2.887	0.016	0.013	0	54.6	55.9	43	155	159	0	28	29
2025	4	2	0	53	9	0.702	-0.046	2.887	0.016	0.013	0	54.6	55.9	45.2	155	159	0	28	29
2025	4	2	1	3	9	0.712	-0.079	2.887	0.023	0.02	0	55	56.3	46.4	155	159	0	27	28
2025	4	2	1	13	9	0.702	-0.082	2.887	0.016	0.016	0	54.6	56.3	44.7	155	159	0	28	28
2025	4	2	1	23	9	0.735	-0.046	2.887	0.02	0.016	0	54.6	56.3	45.6	155	159	0	28	28
2025	4	2	1	33	9	0.719	-0.059	2.884	0.016	0.016	0	54.6	56.3	45.6	155	159	0	28	28
2025	4	2	1	43	9	0.748	-0.056	2.884	0.016	0.016	0	54.2	55.5	62.8	154	158	0	28	29
2025	4	2	1	53	9	0.702	-0.056	2.884	0.016	0.013	0	54.2	55.9	65.8	154	158	0	28	28
2025	4	2	2	3	9	0.732	-0.043	2.884	0.016	0.016	0	54.6	55.9	67.9	154	158	0	27	28
2025	4	2	2	13	9	0.682	-0.059	2.884	0.016	0.016	0	54.2	55.9	68.4	154	158	0	28	28
2025	4	2	2	23	9	0.738	-0.092	2.884	0.016	0.016	0	54.6	55.5	64.5	154	158	0	27	29
2025	4	2	2	33	9	0.758	-0.079	2.884	0.016	0.016	0	53.8	55.5	48.2	153	157	0	28	28
2025	4	2	2	43	9	0.722	-0.072	2.884	0.016	0.016	0	54.6	55.5	50.3	154	157	0	27	28
2025	4	2	2	53	9	0.735	-0.049	2.884	0.016	0.013	0	54.2	55.5	48.6	154	158	0	28	29
2025	4	2	3	3	9	0.719	-0.072	2.884	0.013	0.01	0	54.2	55.9	53.8	154	158	0	28	28
2025	4	2	3	13	9	0.722	-0.046	2.884	0.016	0.016	0	54.2	55.9	51.2	154	158	0	28	28
2025	4	2	3	23	9	0.699	-0.03	2.884	0.016	0.013	0	53.8	55	52.5	153	157	0	28	29
2025	4	2	3	33	9	0.705	-0.062	2.884	0.013	0.01	0	53.8	55.9	46	153	158	0	28	28
2025	4	2	3	43	9	0.741	-0.085	2.884	0.016	0.016	0	53.3	55	47.7	153	157	0	29	29
2025	4	2	3	53	9	0.735	-0.043	2.884	0.016	0.013	0	53.8	55.5	45.6	153	157	0	28	28
2025	4	2	4	3	9	0.748	-0.079	2.884	0.016	0.013	0	53.8	55	45.6	153	157	0	28	29
2025	4	2	4	13	9	0.705	-0.069	2.884	0.016	0.016	0	53.3	55.5	43	152	157	0	28	28
2025	4	2	4	23	9	0.689	-0.069	2.884	0.016	0.013	0	53.3	55	45.6	152	156	0	28	28
2025	4	2	4	33	9	0.735	-0.089	2.884	0.016	0.013	0	53.3	54.6	48.6	152	156	0	28	29
2025	4	2	4	43	9	0.722	-0.072	2.881	0.016	0.013	0	53.8	55	52	152	156	0	27	28
2025	4	2	4	53	9	0.768	-0.079	2.881	0.016	0.013	0	53.3	55	60.2	152	156	0	28	28
2025	4	2	5	3	9	0.728	-0.072	2.881	0.016	0.013	0	53.3	54.6	50.7	152	156	0	28	29
2025	4	2	5	13	9	0.722	-0.072	2.881	0.013	0.01	0	53.8	55	50.3	153	157	0	28	29
2025	4	2	5	23	9	0.712	-0.075	2.881	0.016	0.013	0	53.8	55	47.3	153	157	0	28	29
2025	4	2	5	33	9	0.738	-0.108	2.881	0.016	0.013	0	53.8	54.6	52.5	153	156	0	28	29
2025	4	2	5	43	9	0.774	-0.069	2.881	0.013	0.01	0	53.3	54.6	60.6	152	156	0	28	29
2025	4	2	5	53	9	0.725	-0.026	2.881	0.016	0.013	0	53.3	55	61.5	152	156	0	28	28
2025	4	2	6	3	9	0.741	-0.062	2.881	0.016	0.013	0	53.3	55	60.6	152	156	0	28	28
2025	4	2	6	13	9	0.686	-0.072	2.884	0.016	0.013	0	53.3	54.6	45.6	152	156	0	28	29
2025	4	2	6	23	9	0.745	-0.016	2.884	0.016	0.016	0	53.3	54.6	46	152	156	0	28	29
2025	4	2	6	33	9	0.741	-0.125	2.884	0.016	0.013	0	52.9	54.6	53.3	151	155	0	28	28
2025	4	2	6	43	9	0.705	-0.085	2.881	0.016	0.016	0	53.3	55	55.5	152	156	0	28	28
2025	4	2	6	53	9	0.715	-0.085	2.884	0.016	0.016	0	53.3	54.6	44.3	152	156	0	28	29
2025	4	2	7	3	9	0.732	-0.066	2.884	0.016	0.013	0	52.9	55	44.7	151	156	0	28	28
2025	4	2	7	13	9	0.722	-0.066	2.887	0.016	0.013	0	53.3	54.6	44.3	152	156	0	28	29
2025	4	2	7	23	9	0.715	-0.056	2.884	0.016	0.016	0	53.8	55	45.6	153	157	0	28	29
2025	4	2	7	33	9	0.712	-0.082	2.887	0.013	0.01	0	52.9	54.6	44.3	151	155	0	28	28
2025	4	2	7	43	9	0.732	-0.026	2.887	0.016	0.016	0	53.3	54.6	46.4	152	156	0	28	29
2025	4	2	7	53	9	0.699	-0.052	2.887	0.016	0.016	0	52.9	54.6	45.2	151	155	0	28	28

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	2	8	3	9	0.712	-0.075	2.887	0.016	0.016	0	52.9	54.2	43.4	151	155	0	28	29
2025	4	2	8	13	9	0.709	-0.079	2.884	0.016	0.016	0	52.9	54.2	45.2	150	154	0	27	28
2025	4	2	8	23	9	0.715	-0.056	2.887	0.016	0.016	0	53.3	54.2	43.9	151	155	0	27	29
2025	4	2	8	33	9	0.719	-0.072	2.89	0.016	0.013	0	52	53.8	45.6	149	154	0	28	29
2025	4	2	8	43	9	0.761	-0.03	2.887	0.013	0.01	0	52.5	54.6	45.6	151	155	0	29	28
2025	4	2	8	53	9	0.755	-0.066	2.887	0.016	0.016	0	52.5	53.8	43.9	150	154	0	28	29
2025	4	2	9	3	9	0.735	-0.03	2.887	0.016	0.016	0	52.9	53.8	44.3	151	154	0	28	29
2025	4	2	9	13	9	0.709	-0.046	2.887	0.016	0.013	0	52.5	53.8	44.7	150	154	0	28	29
2025	4	2	9	23	9	0.709	-0.036	2.887	0.016	0.013	0	52.5	53.8	46.9	150	153	0	28	28
2025	4	2	9	33	9	0.696	-0.043	2.887	0.02	0.016	0	52.5	53.8	44.3	150	154	0	28	29
2025	4	2	9	43	9	0.741	-0.079	2.887	0.013	0.01	0	52.5	53.3	47.3	150	153	0	28	29
2025	4	2	9	53	9	0.778	-0.066	2.887	0.016	0.013	0	52.5	53.8	45.2	149	153	0	27	28
2025	4	2	10	3	9	0.712	-0.072	2.89	0.016	0.016	0	53.3	54.6	46.4	152	155	0	28	28
2025	4	2	10	13	9	0.735	-0.082	2.887	0.016	0.016	0	52.5	54.2	47.3	150	154	0	28	28
2025	4	2	10	23	9	0.715	-0.036	2.89	0.016	0.013	0	53.3	54.2	45.6	151	155	0	27	29
2025	4	2	10	33	9	0.715	-0.043	2.89	0.016	0.013	0	52.5	53.8	47.3	150	154	0	28	29
2025	4	2	10	43	9	0.745	-0.082	2.887	0.016	0.013	0	52.9	54.2	46.9	150	154	0	27	28
2025	4	2	10	53	9	0.699	-0.039	2.89	0.016	0.013	0	52	53.8	44.7	150	154	0	29	29
2025	4	2	11	3	9	0.699	-0.056	2.89	0.016	0.016	0	52.5	53.8	49	150	154	0	28	29
2025	4	2	11	13	9	0.712	-0.059	2.89	0.016	0.013	0	52.9	54.2	48.6	151	154	0	28	28
2025	4	2	11	23	9	0.741	-0.059	2.89	0.016	0.016	0	52	53.8	52	149	153	0	28	28
2025	4	2	11	33	9	0.725	-0.043	2.887	0.016	0.013	0	52.5	54.2	55	150	154	0	28	28
2025	4	2	11	43	9	0.705	-0.062	2.887	0.016	0.013	0	52.9	54.6	52.5	151	155	0	28	28
2025	4	2	11	53	9	0.758	-0.049	2.89	0.016	0.016	0	53.3	54.6	51.2	152	155	0	28	28
2025	4	2	12	3	9	0.745	-0.062	2.89	0.016	0.016	0	53.3	54.2	53.8	151	155	0	27	29
2025	4	2	12	13	9	0.735	-0.03	2.89	0.016	0.016	0	54.2	55	56.8	153	156	0	27	28
2025	4	2	12	23	9	0.761	-0.043	2.89	0.016	0.013	0	53.8	55	49	152	156	0	27	28
2025	4	2	12	33	9	0.768	-0.069	2.89	0.013	0.01	0	53.3	55	66.7	152	156	0	28	28
2025	4	2	12	43	9	0.738	-0.082	2.89	0.016	0.016	0	53.3	55	64.9	152	156	0	28	28
2025	4	2	12	53	9	0.735	-0.036	2.89	0.016	0.013	0	53.8	55	70.1	153	156	0	28	28
2025	4	2	13	3	9	0.728	-0.082	2.894	0.016	0.013	0	54.2	55	67.9	154	157	0	28	29
2025	4	2	13	13	9	0.748	-0.033	2.894	0.016	0.013	0	54.6	55.9	53.3	154	158	0	27	28
2025	4	2	13	23	9	0.758	-0.072	2.894	0.016	0.013	0	54.6	55.5	47.7	154	157	0	27	28
2025	4	2	13	33	9	0.748	-0.043	2.894	0.016	0.016	0	54.2	55.9	43.4	154	158	0	28	28
2025	4	2	13	43	9	0.728	-0.043	2.894	0.02	0.016	0	55	56.3	45.2	155	159	0	27	28
2025	4	2	13	53	9	0.712	-0.059	2.894	0.016	0.016	0	55	56.3	44.3	155	159	0	27	28
2025	4	2	14	3	9	0.732	-0.046	2.897	0.016	0.013	0	55.5	56.3	44.3	157	160	0	28	29
2025	4	2	14	13	9	0.715	-0.052	2.897	0.013	0.01	0	55.5	56.8	44.7	156	160	0	27	28
2025	4	2	14	23	9	0.748	-0.043	2.897	0.016	0.016	0	55	56.3	46.4	155	159	0	27	28
2025	4	2	14	33	9	0.761	-0.043	2.897	0.013	0.01	0	54.2	55.9	48.6	154	158	0	28	28
2025	4	2	14	43	9	0.719	-0.036	2.897	0.016	0.013	0	55	56.8	46	156	160	0	28	28
2025	4	2	14	53	9	0.732	-0.059	2.897	0.016	0.016	0	55	56.8	49.5	156	160	0	28	28
2025	4	2	15	3	9	0.758	-0.069	2.897	0.016	0.013	0	55.5	56.8	49.5	156	160	0	27	28
2025	4	2	15	13	9	0.755	-0.092	2.897	0.023	0.02	0	55	56.8	46.9	156	159	0	28	27
2025	4	2	15	23	9	0.712	-0.072	2.897	0.016	0.013	0	55.5	56.3	62.8	156	159	0	27	28
2025	4	2	15	33	9	0.758	-0.072	2.897	0.016	0.016	0	55	56.8	61.5	155	159	0	27	27
2025	4	2	15	43	9	0.732	-0.059	2.897	0.016	0.013	0	55.5	56.3	63.6	156	159	0	27	28
2025	4	2	15	53	9	0.758	-0.072	2.897	0.016	0.013	0	56.3	56.8	65.8	158	160	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	2	16	3	9	0.771	-0.033	2.897	0.016	0.013	0	55.9	56.3	67.5	157	159	0	27	28
2025	4	2	16	13	9	0.715	-0.043	2.9	0.016	0.016	0	56.3	56.8	52	158	160	0	27	28
2025	4	2	16	23	9	0.768	-0.059	2.9	0.016	0.013	0	55.9	56.3	47.3	157	160	0	27	29
2025	4	2	16	33	9	0.741	0	2.9	0.016	0.013	0	55.5	56.3	46.4	157	160	0	28	29
2025	4	2	16	43	9	0.732	-0.059	2.9	0.016	0.013	0	55.9	56.8	45.2	157	160	0	27	28
2025	4	2	16	53	9	0.741	-0.043	2.9	0.016	0.013	0	55.5	57.2	45.6	157	161	0	28	28
2025	4	2	17	3	9	0.764	-0.092	2.9	0.016	0.016	0	55	56.8	47.7	156	160	0	28	28
2025	4	2	17	13	9	0.751	-0.102	2.897	0.016	0.016	0	55	55.9	45.6	156	159	0	28	29
2025	4	2	17	23	9	0.712	-0.066	2.9	0.016	0.013	0	55.5	56.3	44.3	156	159	0	27	28
2025	4	2	17	33	9	0.732	-0.082	2.897	0.016	0.013	0	55.5	56.3	45.6	156	159	0	27	28
2025	4	2	17	43	9	0.758	-0.085	2.897	0.016	0.013	0	55.5	55.9	62.8	156	159	0	27	29
2025	4	2	17	53	9	0.764	-0.072	2.897	0.016	0.013	0	55.5	55.9	64.5	156	159	0	27	29
2025	4	2	18	3	9	0.709	-0.052	2.897	0.016	0.013	0	55.5	56.3	60.6	156	159	0	27	28
2025	4	2	18	13	9	0.732	-0.082	2.897	0.02	0.016	0	55	56.3	53.3	156	159	0	28	28
2025	4	2	18	23	9	0.741	-0.052	2.897	0.016	0.013	0	55.5	56.3	48.2	156	160	0	27	29
2025	4	2	18	33	9	0.709	-0.062	2.897	0.016	0.013	0	55	56.3	46.4	156	159	0	28	28
2025	4	2	18	43	9	0.712	-0.013	2.897	0.016	0.013	0	55	56.8	60.6	156	160	0	28	28
2025	4	2	18	53	9	0.764	-0.092	2.897	0.016	0.016	0	55	56.3	60.6	156	160	0	28	29
2025	4	2	19	3	9	0.748	-0.043	2.894	0.016	0.016	0	55	57.2	47.7	156	160	0	28	27
2025	4	2	19	13	9	0.699	-0.03	2.894	0.02	0.016	0	55.9	56.3	57.6	157	160	0	27	29
2025	4	2	19	23	9	0.719	-0.046	2.894	0.016	0.016	0	55.9	56.8	48.2	157	160	0	27	28
2025	4	2	19	33	9	0.738	-0.072	2.894	0.016	0.013	0	55	56.8	56.8	156	160	0	28	28
2025	4	2	19	43	9	0.712	-0.033	2.894	0.016	0.013	0	55.9	56.8	61.5	157	160	0	27	28
2025	4	2	19	53	9	0.738	-0.056	2.894	0.013	0.01	0	55.5	56.8	49.5	156	160	0	27	28
2025	4	2	20	3	9	0.761	-0.056	2.894	0.02	0.016	0	55	56.8	55.5	156	160	0	28	28
2025	4	2	20	13	9	0.732	-0.066	2.894	0.016	0.016	0	55.5	56.8	47.7	156	160	0	27	28
2025	4	2	20	23	9	0.751	-0.085	2.894	0.016	0.013	0	55.5	56.8	46	156	160	0	27	28
2025	4	2	20	33	9	0.738	-0.072	2.89	0.016	0.013	0	55	56.8	47.3	156	160	0	28	28
2025	4	2	20	43	9	0.781	-0.082	2.89	0.016	0.016	0	55.5	56.3	52.5	156	160	0	27	29
2025	4	2	20	53	9	0.751	-0.039	2.89	0.016	0.013	0	55.5	56.8	66.2	156	160	0	27	28
2025	4	2	21	3	9	0.709	-0.062	2.89	0.016	0.013	0	55.5	56.8	67.9	157	160	0	28	28
2025	4	2	21	13	9	0.768	-0.043	2.89	0.016	0.013	0	55	56.8	68.4	156	160	0	28	28
2025	4	2	21	23	9	0.732	-0.056	2.89	0.016	0.013	0	55.5	56.3	67.5	156	160	0	27	29
2025	4	2	21	33	9	0.715	-0.039	2.887	0.013	0.01	0	55	57.2	65.8	156	161	0	28	28
2025	4	2	21	43	9	0.761	-0.089	2.887	0.016	0.013	0	55	56.3	67.9	156	159	0	28	28
2025	4	2	21	53	9	0.732	-0.069	2.887	0.016	0.016	0	54.2	55.9	68.4	155	159	0	29	29
2025	4	2	22	3	9	0.709	-0.059	2.887	0.016	0.016	0	55	56.3	68.4	156	159	0	28	28
2025	4	2	22	13	9	0.748	-0.052	2.887	0.016	0.013	0	54.6	56.3	68.4	155	159	0	28	28
2025	4	2	22	23	9	0.709	-0.075	2.887	0.016	0.016	0	55	56.3	68.8	155	159	0	27	28
2025	4	2	22	33	9	0.709	-0.098	2.887	0.016	0.016	0	55	55.9	68.4	156	159	0	28	29
2025	4	2	22	43	9	0.722	-0.085	2.884	0.016	0.013	0	54.2	55.9	68.8	154	158	0	28	28
2025	4	2	22	53	9	0.748	-0.052	2.884	0.02	0.016	0	55	56.3	68.8	155	159	0	27	28
2025	4	2	23	3	9	0.725	-0.059	2.884	0.02	0.016	0	54.6	55.9	68.8	155	158	0	28	28
2025	4	2	23	13	9	0.741	-0.072	2.884	0.016	0.013	0	54.2	55.5	68.4	154	158	0	28	29
2025	4	2	23	23	9	0.738	-0.085	2.884	0.013	0.01	0	55	55.5	68.4	155	158	0	27	29
2025	4	2	23	33	9	0.725	-0.059	2.881	0.016	0.016	0	54.2	55.9	68.4	154	158	0	28	28
2025	4	2	23	43	9	0.702	-0.066	2.881	0.016	0.016	0	54.6	55.5	68.8	154	158	0	27	29
2025	4	2	23	53	9	0.738	-0.082	2.881	0.016	0.013	0	54.2	55.9	69.2	154	158	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	3	0	3	9	0.715	-0.052	2.881	0.016	0.016	0	54.2	55.5	68.4	154	158	0	28	29
2025	4	3	0	13	9	0.712	-0.039	2.881	0.013	0.01	0	53.8	55.9	68.8	153	158	0	28	28
2025	4	3	0	23	9	0.689	-0.062	2.881	0.016	0.013	0	54.2	55.5	68.4	154	158	0	28	29
2025	4	3	0	33	9	0.725	-0.062	2.881	0.016	0.016	0	53.8	55.5	69.2	153	158	0	28	29
2025	4	3	0	43	9	0.705	-0.069	2.881	0.016	0.013	0	53.8	55.9	67.9	153	158	0	28	28
2025	4	3	0	53	9	0.728	-0.066	2.881	0.016	0.013	0	53.8	55.5	68.4	153	157	0	28	28
2025	4	3	1	3	9	0.689	-0.052	2.881	0.016	0.016	0	53.8	55.9	69.2	153	158	0	28	28
2025	4	3	1	13	9	0.735	-0.079	2.877	0.016	0.013	0	53.8	55.5	68.8	153	157	0	28	28
2025	4	3	1	23	9	0.692	-0.059	2.877	0.016	0.016	0	54.2	55.5	68.8	154	158	0	28	29
2025	4	3	1	33	9	0.686	-0.049	2.877	0.013	0.01	0	53.8	55.5	68.8	153	157	0	28	28
2025	4	3	1	43	9	0.768	-0.043	2.877	0.016	0.016	0	53.3	54.6	68.8	152	156	0	28	29
2025	4	3	1	53	9	0.712	-0.098	2.877	0.013	0.01	0	53.8	55	68.8	152	157	0	27	29
2025	4	3	2	3	9	0.719	-0.052	2.877	0.016	0.013	0	53.8	54.6	68.8	152	156	0	27	29
2025	4	3	2	13	9	0.709	-0.013	2.877	0.016	0.013	0	53.3	55.5	68.8	152	157	0	28	28
2025	4	3	2	23	9	0.696	-0.082	2.877	0.013	0.01	0	53.8	55	68.8	152	156	0	27	28
2025	4	3	2	33	9	0.715	-0.036	2.877	0.016	0.016	0	52.9	54.6	68.8	152	156	0	29	29
2025	4	3	2	43	9	0.702	-0.056	2.877	0.016	0.013	0	53.3	55	68.4	152	156	0	28	28
2025	4	3	2	53	9	0.709	-0.062	2.877	0.016	0.013	0	52.9	54.6	68.4	151	156	0	28	29
2025	4	3	3	3	9	0.715	-0.102	2.877	0.016	0.016	0	52.9	55	68.8	151	156	0	28	28
2025	4	3	3	13	9	0.679	-0.066	2.877	0.016	0.016	0	52.5	55	68.4	151	156	0	29	28
2025	4	3	3	23	9	0.719	-0.072	2.877	0.016	0.013	0	52.9	54.6	68.4	151	156	0	28	29
2025	4	3	3	33	9	0.719	-0.062	2.877	0.016	0.016	0	52.9	54.2	68.8	151	155	0	28	29
2025	4	3	3	43	9	0.715	-0.069	2.877	0.016	0.013	0	52.5	54.2	69.2	151	155	0	29	29
2025	4	3	3	53	9	0.732	-0.075	2.874	0.016	0.013	0	52.9	54.2	68.4	151	155	0	28	29
2025	4	3	4	3	9	0.738	-0.069	2.874	0.016	0.013	0	52.9	54.2	67.9	151	155	0	28	29
2025	4	3	4	13	9	0.722	-0.059	2.874	0.013	0.01	0	52.9	54.6	68.4	151	155	0	28	28
2025	4	3	4	23	9	0.709	-0.062	2.874	0.016	0.013	0	52.9	54.2	68.4	151	155	0	28	29
2025	4	3	4	33	9	0.728	-0.049	2.874	0.016	0.013	0	52.5	54.6	68.4	150	155	0	28	28
2025	4	3	4	43	9	0.712	-0.075	2.874	0.016	0.016	0	52.5	54.2	68.4	150	155	0	28	29
2025	4	3	4	53	9	0.705	-0.039	2.874	0.016	0.016	0	52.9	54.2	68.4	151	155	0	28	29
2025	4	3	5	3	9	0.741	-0.069	2.874	0.016	0.013	0	52.5	53.8	68.4	150	154	0	28	29
2025	4	3	5	13	9	0.686	-0.043	2.874	0.016	0.013	0	52.5	54.6	67.9	150	155	0	28	28
2025	4	3	5	23	9	0.745	-0.056	2.874	0.02	0.016	0	52.5	54.2	68.4	150	154	0	28	28
2025	4	3	5	33	9	0.738	-0.069	2.874	0.016	0.016	0	52	53.8	68.8	149	154	0	28	29
2025	4	3	5	43	9	0.686	-0.095	2.874	0.016	0.013	0	52.5	54.2	67.9	150	154	0	28	28
2025	4	3	5	53	9	0.709	-0.066	2.874	0.016	0.013	0	52.5	53.8	68.8	150	154	0	28	29
2025	4	3	6	3	9	0.692	-0.046	2.874	0.016	0.016	0	52.5	53.8	68.4	150	154	0	28	29
2025	4	3	6	13	9	0.728	-0.079	2.874	0.013	0.01	0	52	53.3	68.8	149	153	0	28	29
2025	4	3	6	23	9	0.709	-0.052	2.874	0.016	0.016	0	52	53.8	68.4	149	154	0	28	29
2025	4	3	6	33	9	0.735	-0.056	2.874	0.016	0.013	0	51.6	53.3	68.8	149	153	0	29	29
2025	4	3	6	43	9	0.709	-0.092	2.874	0.016	0.013	0	52.5	53.8	68.4	150	154	0	28	29
2025	4	3	6	53	9	0.741	-0.085	2.874	0.016	0.013	0	51.6	54.2	69.2	149	154	0	29	28
2025	4	3	7	3	9	0.673	-0.039	2.874	0.016	0.016	0	52.5	54.2	68.4	150	155	0	28	29
2025	4	3	7	13	9	0.722	-0.092	2.874	0.016	0.013	0	52	53.3	68.8	149	153	0	28	29
2025	4	3	7	23	9	0.722	-0.089	2.874	0.016	0.016	0	52	54.2	67.9	149	154	0	28	28
2025	4	3	7	33	9	0.722	-0.049	2.874	0.016	0.016	0	52	54.2	63.2	149	154	0	28	28
2025	4	3	7	43	9	0.725	-0.043	2.874	0.016	0.013	0	52	53.8	68.4	150	154	0	29	29
2025	4	3	7	53	9	0.705	-0.069	2.877	0.016	0.013	0	51.6	52.9	47.7	148	152	0	28	29

Mazourka (0354)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	
2025	4	3	8	3	9	0.735	-0.052	2.877	0.016	0.013	0	51.6	53.3	46.9	148	152	0	28	28	
2025	4	3	8	13	9	0.715	-0.039	2.877	0.016	0.016	0	51.6	52.9	46.4	148	152	0	28	29	
2025	4	3	8	23	9	0.699	-0.056	2.877	0.016	0.013	0	51.6	53.3	46.9	148	152	0	28	28	
2025	4	3	8	33	9	0.722	-0.039	2.877	0.016	0.013	0	50.7	52.9	48.2	147	152	0	29	29	
2025	4	3	8	43	9	0.751	-0.085	2.881	0.016	0.016	0	50.7	52.9	47.7	147	152	0	29	29	
2025	4	3	8	53	9	0.719	-0.095	2.881	0.016	0.016	0	52	52.9	46.9	148	152	0	27	29	
2025	4	3	9	3	9	0.725	-0.056	2.884	0.016	0.016	0	51.6	53.3	44.3	148	153	0	28	29	
2025	4	3	9	13	9	0.771	-0.043	2.881	0.013	0.01	0	51.2	52.5	46.9	147	151	0	28	29	
2025	4	3	9	23	9	0.732	-0.056	2.881	0.016	0.013	0	51.2	53.3	45.6	147	152	0	28	28	
2025	4	3	9	33	9	0.699	-0.082	2.881	0.016	0.016	0	51.6	53.3	44.7	148	153	0	28	29	
2025	4	3	9	43	9	0.735	-0.056	2.884	0.016	0.016	0	51.6	53.3	46.4	148	152	0	28	28	
2025	4	3	9	53	9	0.728	-0.075	2.887	0.016	0.016	0	51.6	52.9	45.2	148	152	0	28	29	
2025	4	3	10	3	9	0.725	-0.056	2.884	0.016	0.013	0	52	53.8	49.9	149	153	0	28	28	
2025	4	3	10	13	9	0.725	-0.062	2.884	0.016	0.013	0	52	53.3	46.9	149	153	0	28	29	
2025	4	3	10	23	9	0.705	-0.075	2.884	0.016	0.013	0	51.6	53.3	47.7	148	153	0	28	29	
2025	4	3	10	33	9	0.751	-0.026	2.884	0.016	0.013	0	52	53.3	51.6	149	153	0	28	29	
2025	4	3	10	43	9	0.722	-0.062	2.887	0.016	0.016	0	52	53.8	49	149	153	0	28	28	
2025	4	3	10	53	9	0.755	-0.082	2.89	0.02	0.016	0	51.6	53.8	46.4	149	154	0	29	29	
2025	4	3	11	3	9	0.705	-0.059	2.89	0.016	0.013	0	52	54.2	48.6	150	154	0	29	28	
2025	4	3	11	13	9	0.692	-0.072	2.89	0.013	0.01	0	52	54.2	62.8	150	154	0	29	28	
2025	4	3	11	23	9	0.748	-0.062	2.894	0.016	0.013	0	52	54.2	47.7	149	154	0	28	28	
2025	4	3	11	33	9	0.748	-0.052	2.894	0.016	0.013	0	52	53.8	54.6	150	154	0	29	29	
2025	4	3	11	43	9	0.738	-0.043	2.894	0.013	0.01	0	52.5	54.6	66.7	150	154	0	28	27	
2025	4	3	11	53	9	0.781	-0.079	2.894	0.016	0.013	0	52	53.3	67.9	149	153	0	28	29	
2025	4	3	12	3	9	0.732	-0.059	2.897	0.016	0.013	0	52.5	54.2	64.5	150	155	0	28	29	
2025	4	3	12	13	9	0.712	-0.03	2.897	0.016	0.016	0	52.5	54.6	67.1	150	155	0	28	28	
2025	4	3	12	23	9	0.784	-0.056	2.9	0.02	0.016	0	52.5	54.2	51.2	150	154	0	28	28	
2025	4	3	12	33	9	0.748	-0.095	2.9	0.016	0.013	0	52.5	54.2	66.7	150	155	0	28	29	
2025	4	3	12	43	9	0.738	-0.072	2.9	0.016	0.013	0	53.3	54.6	58.5	152	156	0	28	29	
2025	4	3	12	53	9	0.748	-0.092	2.904	0.016	0.016	0	53.8	55.5	46.9	152	157	0	27	28	
2025	4	3	13	3	9	0.732	-0.013	2.904	0.013	0.01	0	53.8	55.9	66.2	153	158	0	28	28	
2025	4	3	13	13	9	0.725	-0.03	2.91	0.016	0.013	0	53.8	55	48.6	153	157	0	28	29	
2025	4	3	13	23	9	0.735	-0.072	2.91	0.016	0.016	0	54.2	55.5	58	153	157	0	27	28	
2025	4	3	13	33	9	0.751	-0.079	2.913	0.02	0.016	0	54.2	55.5	55	154	158	0	28	29	
2025	4	3	13	43	9	0.758	-0.043	2.92	0.016	0.013	0	54.6	56.3	66.2	155	159	0	28	28	
2025	4	3	13	53	9	0.748	-0.039	2.92	0.016	0.013	0	54.6	56.3	64.9	155	159	0	28	28	
2025	4	3	14	3	9	0.738	-0.072	2.923	0.016	0.013	0	55	55.5	64.5	155	158	0	27	29	
2025	4	3	14	13	9	0.764	-0.049	2.92	0.016	0.013	0	55.5	56.3	49.9	156	159	0	27	28	
2025	4	3	14	23	9	0.758	-0.079	2.923	0.016	0.013	0	55.5	56.8	60.6	156	160	0	27	28	
2025	4	3	14	33	9	0.741	-0.046	2.927	0.016	0.013	0	55.9	56.3	55	157	160	0	27	29	
2025	4	3	14	43	9	0.741	-0.046	2.93	0.016	0.016	0	55.5	57.2	66.7	157	161	0	28	28	
2025	4	3	14	53	9	0.751	-0.075	2.933	0.016	0.013	0	55.5	57.6	68.4	157	161	0	28	27	
2025	4	3	15	3	9	0.705	-0.069	2.933	0.016	0.013	0	55.9	56.8	67.1	157	160	0	27	28	
2025	4	3	15	13	9	0.732	-0.062	2.936	0.016	0.013	0	55.9	56.8	66.2	157	160	0	27	28	
2025	4	3	15	23	9	0.705	-0.036	2.936	0.016	0.013	0	55.9	56.8	68.4	157	160	0	27	28	
2025	4	3	15	33	9	0.738	-0.062	2.936	0.016	0.016	0	55.9	56.8	67.9	157	160	0	27	28	
2025	4	3	15	43	9	0.794	-0.03	2.94	0.02	0.016	0	56.3	56.3	67.1	157	160	0	26	29	
2025	4	3	15	53	9	0.761	-0.03	2.94	0.016	0.016	0	55.9	57.2	62.4	158	161	0	28	28	

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	3	16	3	9	0.758	-0.069	2.943	0.013	0.01	0	55.5	56.8	52	157	160	0	28	28
2025	4	3	16	13	9	0.758	-0.056	2.943	0.016	0.013	0	55.5	56.8	65.4	156	160	0	27	28
2025	4	3	16	23	9	0.801	-0.03	2.943	0.01	0.007	0	56.3	57.6	64.5	158	162	0	27	28
2025	4	3	16	33	9	0.761	-0.049	2.946	0.016	0.013	0	56.3	57.2	64.5	158	161	0	27	28
2025	4	3	16	43	9	0.787	-0.056	2.946	0.016	0.013	0	55.9	57.2	66.2	157	161	0	27	28
2025	4	3	16	53	9	0.791	-0.026	2.949	0.016	0.013	0	55.9	57.2	66.2	158	161	0	28	28
2025	4	3	17	3	9	0.764	-0.03	2.953	0.016	0.016	0	56.3	57.2	64.9	158	161	0	27	28
2025	4	3	17	13	9	0.781	-0.052	2.959	0.016	0.013	0	56.3	57.2	64.9	157	161	0	26	28
2025	4	3	17	23	9	0.758	-0.059	2.966	0.016	0.016	0	55.9	57.2	64.5	157	161	0	27	28
2025	4	3	17	33	9	0.807	-0.026	2.969	0.016	0.016	0	55.5	56.8	66.2	157	160	0	28	28
2025	4	3	17	43	9	0.771	-0.046	2.969	0.013	0.01	0	55.9	56.8	64.9	157	160	0	27	28
2025	4	3	17	53	9	0.778	-0.007	2.972	0.016	0.016	0	56.3	57.2	64.1	158	161	0	27	28
2025	4	3	18	3	9	0.764	-0.03	2.972	0.02	0.016	0	55.9	57.6	52.5	158	162	0	28	28
2025	4	3	18	13	9	0.778	-0.075	2.976	0.016	0.016	0	56.3	57.2	46.4	158	161	0	27	28
2025	4	3	18	23	9	0.784	-0.03	2.976	0.016	0.013	0	56.3	57.6	67.9	158	162	0	27	28
2025	4	3	18	33	9	0.771	-0.039	2.979	0.016	0.013	0	56.3	57.2	67.5	158	161	0	27	28
2025	4	3	18	43	9	0.781	-0.079	2.979	0.016	0.013	0	55.9	57.2	63.6	157	161	0	27	28
2025	4	3	18	53	9	0.787	-0.092	2.982	0.016	0.013	0	56.3	57.2	66.7	158	161	0	27	28
2025	4	3	19	3	9	0.787	-0.03	2.982	0.01	0.007	0	55.9	57.6	59.8	158	162	0	28	28
2025	4	3	19	13	9	0.817	-0.052	2.986	0.016	0.016	0	55.9	58	65.4	158	162	0	28	27
2025	4	3	19	23	9	0.784	-0.043	2.986	0.013	0.01	0	56.8	57.6	64.1	159	162	0	27	28
2025	4	3	19	33	9	0.791	-0.079	2.995	0.016	0.013	0	56.3	57.6	62.8	158	162	0	27	28
2025	4	3	19	43	9	0.781	-0.043	2.999	0.016	0.016	0	55.9	58	50.7	158	163	0	28	28
2025	4	3	19	53	9	0.804	-0.056	3.005	0.02	0.016	0	56.3	57.6	58.9	158	162	0	27	28
2025	4	3	20	3	9	0.791	0	3.005	0.016	0.013	0	56.3	57.6	54.6	158	162	0	27	28
2025	4	3	20	13	9	0.791	-0.043	3.009	0.02	0.016	0	56.3	58	60.2	159	162	0	28	27
2025	4	3	20	23	9	0.794	-0.043	3.009	0.013	0.01	0	56.8	58	45.6	159	163	0	27	28
2025	4	3	20	33	9	0.807	-0.02	3.012	0.016	0.016	0	56.3	57.6	64.5	159	162	0	28	28
2025	4	3	20	43	9	0.751	-0.02	3.012	0.016	0.016	0	55.9	57.6	46	158	162	0	28	28
2025	4	3	20	53	9	0.807	-0.059	3.015	0.016	0.013	0	56.3	57.6	58.5	158	162	0	27	28
2025	4	3	21	3	9	0.807	-0.043	3.015	0.016	0.016	0	56.8	57.2	61.1	159	162	0	27	29
2025	4	3	21	13	9	0.84	-0.049	3.018	0.016	0.013	0	55.9	57.6	49.9	158	162	0	28	28
2025	4	3	21	23	9	0.817	-0.069	3.022	0.016	0.016	0	56.3	57.6	55.9	158	162	0	27	28
2025	4	3	21	33	9	0.827	-0.052	3.031	0.016	0.013	0	56.3	57.6	63.6	158	162	0	27	28
2025	4	3	21	43	9	0.801	-0.046	3.038	0.016	0.013	0	55.5	57.6	64.9	158	162	0	29	28
2025	4	3	21	53	9	0.791	-0.036	3.041	0.016	0.016	0	55.9	57.6	66.2	158	162	0	28	28
2025	4	3	22	3	9	0.833	-0.082	3.041	0.016	0.013	0	55.5	57.2	67.1	157	161	0	28	28
2025	4	3	22	13	9	0.833	-0.046	3.045	0.016	0.013	0	55.9	57.2	67.5	157	161	0	27	28
2025	4	3	22	23	9	0.774	-0.069	3.045	0.016	0.013	0	55.9	57.2	67.1	157	161	0	27	28
2025	4	3	22	33	9	0.82	-0.056	3.048	0.016	0.013	0	55.9	57.6	67.1	158	162	0	28	28
2025	4	3	22	43	9	0.83	-0.013	3.048	0.02	0.016	0	55.9	57.2	66.7	158	161	0	28	28
2025	4	3	22	53	9	0.823	-0.043	3.051	0.016	0.013	0	55.5	57.6	44.3	157	162	0	28	28
2025	4	3	23	3	9	0.837	-0.043	3.054	0.016	0.013	0	55.9	57.6	41.7	158	162	0	28	28
2025	4	3	23	13	9	0.83	-0.069	3.058	0.02	0.016	0	55.9	57.2	55.5	157	161	0	27	28
2025	4	3	23	23	9	0.82	-0.062	3.068	0.016	0.013	0	55.9	57.6	63.6	157	162	0	27	28
2025	4	3	23	33	9	0.856	-0.069	3.071	0.013	0.01	0	55.5	57.2	65.4	157	161	0	28	28
2025	4	3	23	43	9	0.82	-0.095	3.074	0.016	0.013	0	55.9	57.6	64.9	158	162	0	28	28
2025	4	3	23	53	9	0.814	-0.069	3.077	0.016	0.016	0	55.5	57.6	65.8	157	161	0	28	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	4	0	3	9	0.86	-0.039	3.077	0.016	0.013	0	55.9	56.8	65.4	157	161	0	27	29
2025	4	4	0	13	9	0.833	-0.082	3.077	0.016	0.013	0	55.9	57.2	64.5	157	161	0	27	28
2025	4	4	0	23	9	0.873	-0.062	3.081	0.016	0.013	0	55	57.2	65.8	156	161	0	28	28
2025	4	4	0	33	9	0.823	-0.039	3.081	0.013	0.01	0	55.5	57.6	61.1	157	162	0	28	28
2025	4	4	0	43	9	0.837	-0.082	3.084	0.016	0.016	0	55	57.2	56.8	156	161	0	28	28
2025	4	4	0	53	9	0.86	0	3.087	0.016	0.013	0	55.5	57.2	44.3	156	161	0	27	28
2025	4	4	1	3	9	0.866	-0.089	3.091	0.013	0.01	0	55.5	56.8	46	157	161	0	28	29
2025	4	4	1	13	9	0.869	-0.039	3.097	0.016	0.013	0	55.5	57.2	46	157	161	0	28	28
2025	4	4	1	23	9	0.833	-0.033	3.104	0.016	0.016	0	55.5	57.2	48.6	157	161	0	28	28
2025	4	4	1	33	9	0.869	-0.033	3.107	0.016	0.016	0	55.5	57.2	45.2	157	161	0	28	28
2025	4	4	1	43	9	0.879	-0.059	3.11	0.016	0.013	0	55.5	57.2	53.8	157	161	0	28	28
2025	4	4	1	53	9	0.84	-0.052	3.11	0.013	0.01	0	55.5	57.2	64.1	157	161	0	28	28
2025	4	4	2	3	9	0.873	-0.043	3.114	0.013	0.01	0	55.5	57.2	64.9	156	161	0	27	28
2025	4	4	2	13	9	0.817	-0.079	3.114	0.016	0.013	0	55.9	56.8	61.9	157	161	0	27	29
2025	4	4	2	23	9	0.899	-0.036	3.117	0.02	0.016	0	55	57.6	52.5	156	161	0	28	27
2025	4	4	2	33	9	0.84	-0.062	3.117	0.016	0.013	0	55	57.2	57.2	156	161	0	28	28
2025	4	4	2	43	9	0.873	-0.02	3.12	0.013	0.01	0	55	56.8	63.2	156	161	0	28	29
2025	4	4	2	53	9	0.876	-0.062	3.13	0.016	0.013	0	55	56.8	63.2	156	160	0	28	28
2025	4	4	3	3	9	0.837	-0.056	3.136	0.016	0.016	0	55	56.3	64.1	156	160	0	28	29
2025	4	4	3	13	9	0.863	-0.059	3.14	0.016	0.016	0	55	56.3	65.4	156	160	0	28	29
2025	4	4	3	23	9	0.879	-0.033	3.143	0.013	0.01	0	54.2	56.8	66.7	155	160	0	29	28
2025	4	4	3	33	9	0.902	-0.052	3.143	0.016	0.013	0	54.6	56.8	67.9	155	160	0	28	28
2025	4	4	3	43	9	0.869	-0.046	3.146	0.013	0.01	0	55	56.3	61.9	156	160	0	28	29
2025	4	4	3	53	9	0.853	-0.062	3.146	0.013	0.01	0	55	56.3	64.5	156	160	0	28	29
2025	4	4	4	3	9	0.869	-0.056	3.15	0.013	0.01	0	55	56.3	61.9	156	160	0	28	29
2025	4	4	4	13	9	0.876	-0.046	3.15	0.016	0.013	0	55	56.8	64.5	156	160	0	28	28
2025	4	4	4	23	9	0.896	-0.079	3.153	0.02	0.016	0	55	56.8	64.9	156	160	0	28	28
2025	4	4	4	33	9	0.883	-0.056	3.153	0.016	0.013	0	55	56.8	64.9	156	160	0	28	28
2025	4	4	4	43	9	0.876	-0.082	3.159	0.016	0.013	0	55	56.8	63.6	156	160	0	28	28
2025	4	4	4	53	9	0.892	-0.095	3.166	0.016	0.016	0	55	56.3	63.6	156	160	0	28	29
2025	4	4	5	3	9	0.866	-0.026	3.169	0.013	0.01	0	55	57.2	62.4	156	161	0	28	28
2025	4	4	5	13	9	0.896	-0.02	3.173	0.016	0.013	0	55.5	56.8	56.8	156	161	0	27	29
2025	4	4	5	23	9	0.915	-0.059	3.176	0.016	0.013	0	55.5	57.2	48.6	157	161	0	28	28
2025	4	4	5	33	9	0.883	-0.039	3.179	0.016	0.013	0	55	56.8	51.6	156	161	0	28	29
2025	4	4	5	43	9	0.889	-0.059	3.179	0.016	0.016	0	55.5	57.2	54.6	157	162	0	28	29
2025	4	4	5	53	9	0.928	-0.046	3.179	0.016	0.016	0	55	56.8	59.3	156	161	0	28	29
2025	4	4	6	3	9	0.909	-0.049	3.182	0.016	0.013	0	55.9	57.2	48.2	157	161	0	27	28
2025	4	4	6	13	9	0.889	-0.066	3.182	0.016	0.013	0	55	56.8	46.4	156	161	0	28	29
2025	4	4	6	23	9	0.955	-0.089	3.186	0.016	0.013	0	55	56.8	52	156	160	0	28	28
2025	4	4	6	33	9	0.886	-0.039	3.186	0.016	0.013	0	55.5	57.2	48.6	157	161	0	28	28
2025	4	4	6	43	9	0.922	-0.039	3.189	0.01	0.007	0	55.5	56.8	57.6	157	161	0	28	29
2025	4	4	6	53	9	0.899	-0.082	3.189	0.016	0.016	0	55.5	56.8	53.8	157	161	0	28	29
2025	4	4	7	3	9	0.915	-0.069	3.192	0.013	0.01	0	55.5	57.6	43	157	162	0	28	28
2025	4	4	7	13	9	0.902	-0.075	3.199	0.016	0.016	0	55.5	57.6	43.9	157	162	0	28	28
2025	4	4	7	23	9	0.919	-0.056	3.199	0.013	0.01	0	55.9	57.6	42.1	158	162	0	28	28
2025	4	4	7	33	9	0.912	-0.069	3.205	0.016	0.013	0	55.9	57.6	42.6	158	162	0	28	28
2025	4	4	7	43	9	0.906	-0.062	3.205	0.016	0.016	0	55.5	57.2	41.7	157	162	0	28	29
2025	4	4	7	53	9	0.915	-0.082	3.209	0.016	0.013	0	55.5	57.2	41.3	157	161	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	4	8	3	9	0.919	-0.039	3.209	0.016	0.016	0	55.9	57.6	40.9	158	162	0	28	28
2025	4	4	8	13	9	0.922	-0.069	3.212	0.013	0.01	0	55.5	57.2	42.1	157	162	0	28	29
2025	4	4	8	23	9	0.906	-0.052	3.215	0.013	0.01	0	55.5	57.2	42.1	157	161	0	28	28
2025	4	4	8	33	9	0.915	-0.059	3.215	0.016	0.013	0	55.9	57.2	43.4	158	161	0	28	28
2025	4	4	8	43	9	0.883	-0.059	3.215	0.013	0.01	0	55.9	57.6	43	158	162	0	28	28
2025	4	4	8	53	9	0.909	-0.023	3.219	0.016	0.016	0	56.3	57.2	43	158	162	0	27	29
2025	4	4	9	3	9	0.896	-0.049	3.219	0.016	0.013	0	55.9	57.2	43.9	158	162	0	28	29
2025	4	4	9	13	9	0.935	-0.066	3.222	0.013	0.01	0	55.5	57.6	43	157	162	0	28	28
2025	4	4	9	23	9	0.892	-0.026	3.222	0.013	0.01	0	55.9	57.6	42.6	158	163	0	28	29
2025	4	4	9	33	9	0.951	-0.075	3.225	0.016	0.016	0	55.9	57.2	41.7	158	162	0	28	29
2025	4	4	9	43	9	0.912	-0.03	3.225	0.016	0.013	0	55.5	57.2	43.4	157	162	0	28	29
2025	4	4	9	53	9	0.942	-0.062	3.225	0.016	0.013	0	55.5	56.8	43.9	157	161	0	28	29
2025	4	4	10	3	9	0.899	-0.069	3.228	0.016	0.013	0	55.9	57.6	52.5	158	162	0	28	28
2025	4	4	10	13	9	0.902	-0.033	3.228	0.016	0.013	0	55.9	57.6	46	158	163	0	28	29
2025	4	4	10	23	9	0.912	-0.023	3.232	0.016	0.013	0	55.5	56.8	43.9	157	161	0	28	29
2025	4	4	10	33	9	0.932	-0.059	3.232	0.016	0.013	0	55.5	57.2	42.1	156	161	0	27	28
2025	4	4	10	43	9	0.922	-0.039	3.235	0.013	0.01	0	55.5	57.2	45.2	157	161	0	28	28
2025	4	4	10	53	9	0.892	-0.033	3.235	0.013	0.01	0	55.5	57.6	44.3	157	162	0	28	28
2025	4	4	11	3	9	0.938	-0.043	3.235	0.016	0.013	0	55.5	56.8	47.7	157	161	0	28	29
2025	4	4	11	13	9	0.961	-0.039	3.235	0.013	0.01	0	55.9	57.2	58	157	161	0	27	28
2025	4	4	11	23	9	0.935	-0.049	3.238	0.016	0.013	0	55.5	56.8	54.2	157	161	0	28	29
2025	4	4	11	33	9	0.955	-0.052	3.238	0.01	0.007	0	56.3	57.2	59.3	158	162	0	27	29
2025	4	4	11	43	9	0.951	-0.072	3.238	0.016	0.013	0	55.9	57.2	64.1	158	162	0	28	29
2025	4	4	11	53	9	0.965	-0.066	3.238	0.013	0.01	0	56.3	57.6	64.9	158	162	0	27	28
2025	4	4	12	3	9	0.925	-0.039	3.238	0.016	0.013	0	55.9	57.6	61.9	158	162	0	28	28
2025	4	4	12	13	9	0.912	-0.069	3.238	0.013	0.01	0	55.9	58	61.5	158	163	0	28	28
2025	4	4	12	23	9	0.915	-0.043	3.238	0.016	0.016	0	55.9	57.6	64.9	158	163	0	28	29
2025	4	4	12	33	9	0.928	-0.075	3.238	0.016	0.016	0	56.3	58	65.8	158	163	0	27	28
2025	4	4	12	43	9	0.925	-0.039	3.238	0.013	0.01	0	55.9	57.6	66.2	158	163	0	28	29
2025	4	4	12	53	9	0.925	-0.056	3.238	0.016	0.013	0	55.9	58	57.2	157	163	0	27	28
2025	4	4	13	3	9	0.915	-0.026	3.238	0.013	0.01	0	56.3	57.6	48.2	158	162	0	27	28
2025	4	4	13	13	9	0.935	-0.056	3.238	0.013	0.01	0	55.5	57.6	65.4	157	162	0	28	28
2025	4	4	13	23	9	0.935	-0.066	3.238	0.016	0.013	0	55.9	58	52.9	157	163	0	27	28
2025	4	4	13	33	9	0.922	-0.026	3.241	0.016	0.013	0	55.9	57.6	43.9	158	162	0	28	28
2025	4	4	13	43	9	0.902	-0.049	3.238	0.016	0.013	0	56.3	57.6	53.3	158	162	0	27	28
2025	4	4	13	53	9	0.909	-0.033	3.238	0.013	0.01	0	55.9	57.6	66.2	157	162	0	27	28
2025	4	4	14	3	9	0.919	-0.066	3.238	0.016	0.016	0	55.9	58	66.2	157	163	0	27	28
2025	4	4	14	13	9	0.919	-0.023	3.241	0.013	0.01	0	56.3	58	45.6	158	163	0	27	28
2025	4	4	14	23	9	0.922	-0.007	3.238	0.013	0.01	0	55.9	58	61.1	158	163	0	28	28
2025	4	4	14	33	9	0.915	-0.066	3.238	0.016	0.013	0	56.3	57.6	66.7	158	163	0	27	29
2025	4	4	14	43	9	0.922	-0.03	3.238	0.013	0.01	0	55.9	57.6	55	158	163	0	28	29
2025	4	4	14	53	9	0.922	-0.039	3.238	0.016	0.013	0	55.9	57.6	54.6	158	162	0	28	28
2025	4	4	15	3	9	0.906	-0.03	3.235	0.016	0.013	0	56.3	58	43	159	162	0	28	27
2025	4	4	15	13	9	0.932	-0.049	3.235	0.016	0.016	0	56.3	58	41.7	159	163	0	28	28
2025	4	4	15	23	9	0.942	-0.03	3.235	0.016	0.013	0	57.2	58	52	160	163	0	27	28
2025	4	4	15	33	9	0.948	-0.059	3.232	0.016	0.013	0	56.8	58	47.7	159	163	0	27	28
2025	4	4	15	43	9	0.948	-0.049	3.232	0.013	0.01	0	57.2	58	58.5	160	163	0	27	28
2025	4	4	15	53	9	0.925	-0.036	3.225	0.016	0.013	0	57.2	58	45.2	160	163	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	4	16	3	9	0.951	-0.039	3.219	0.016	0.016	0	56.3	58	54.6	159	163	0	28	28
2025	4	4	16	13	9	0.892	-0.026	3.219	0.016	0.013	0	57.2	58.5	43.9	160	163	0	27	27
2025	4	4	16	23	9	0.925	-0.056	3.215	0.016	0.013	0	56.8	58	45.2	160	163	0	28	28
2025	4	4	16	33	9	0.935	-0.036	3.215	0.013	0.01	0	56.8	58.5	43.4	160	163	0	28	27
2025	4	4	16	43	9	0.928	-0.069	3.212	0.016	0.016	0	56.8	57.6	53.3	159	162	0	27	28
2025	4	4	16	53	9	0.915	-0.072	3.209	0.016	0.013	0	56.8	58	47.3	159	163	0	27	28
2025	4	4	17	3	9	0.948	-0.016	3.209	0.013	0.01	0	56.8	58	52.5	159	163	0	27	28
2025	4	4	17	13	9	0.919	-0.056	3.209	0.016	0.016	0	56.8	58	53.8	159	163	0	27	28
2025	4	4	17	23	9	0.906	-0.023	3.205	0.016	0.013	0	56.3	58	66.2	159	163	0	28	28
2025	4	4	17	33	9	0.932	-0.036	3.205	0.016	0.013	0	56.3	57.6	67.5	158	162	0	27	28
2025	4	4	17	43	9	0.928	-0.069	3.202	0.013	0.01	0	56.3	57.6	66.2	158	162	0	27	28
2025	4	4	17	53	9	0.879	-0.033	3.202	0.016	0.013	0	55.9	57.6	65.4	158	162	0	28	28
2025	4	4	18	3	9	0.915	-0.043	3.199	0.016	0.013	0	56.3	57.6	65.4	158	162	0	27	28
2025	4	4	18	13	9	0.883	-0.046	3.196	0.016	0.013	0	56.3	57.6	65.4	158	162	0	27	28
2025	4	4	18	23	9	0.892	-0.062	3.192	0.016	0.013	0	56.3	58	63.6	158	162	0	27	27
2025	4	4	18	33	9	0.892	-0.056	3.186	0.016	0.013	0	56.3	57.6	64.1	158	162	0	27	28
2025	4	4	18	43	9	0.883	-0.046	3.176	0.016	0.016	0	55.9	58	64.1	158	163	0	28	28
2025	4	4	18	53	9	0.919	-0.02	3.176	0.013	0.01	0	56.8	58	64.9	159	162	0	27	27
2025	4	4	19	3	9	0.928	-0.013	3.173	0.016	0.013	0	56.3	58	65.4	159	163	0	28	28
2025	4	4	19	13	9	0.896	-0.049	3.169	0.016	0.013	0	56.8	58	65.8	159	163	0	27	28
2025	4	4	19	23	9	0.896	-0.069	3.169	0.016	0.013	0	55.9	58	65.8	158	162	0	28	27
2025	4	4	19	33	9	0.853	-0.062	3.166	0.013	0.01	0	56.3	57.6	66.2	159	162	0	28	28
2025	4	4	19	43	9	0.896	-0.052	3.166	0.016	0.013	0	56.3	57.2	66.7	159	162	0	28	29
2025	4	4	19	53	9	0.863	-0.069	3.163	0.016	0.013	0	56.3	57.6	60.2	158	162	0	27	28
2025	4	4	20	3	9	0.863	-0.082	3.163	0.016	0.016	0	55.9	57.6	60.2	158	162	0	28	28
2025	4	4	20	13	9	0.889	-0.059	3.159	0.016	0.013	0	55.9	57.6	57.2	158	162	0	28	28
2025	4	4	20	23	9	0.915	-0.033	3.156	0.01	0.007	0	55.9	58.5	55.9	158	163	0	28	27
2025	4	4	20	33	9	0.922	-0.069	3.156	0.016	0.013	0	55.9	58	64.9	158	162	0	28	27
2025	4	4	20	43	9	0.866	-0.023	3.15	0.01	0.007	0	55.9	57.6	44.7	158	162	0	28	28
2025	4	4	20	53	9	0.899	-0.049	3.146	0.016	0.016	0	56.3	57.6	63.2	158	162	0	27	28
2025	4	4	21	3	9	0.873	-0.033	3.14	0.016	0.016	0	55.9	57.6	41.7	158	162	0	28	28
2025	4	4	21	13	9	0.86	-0.02	3.133	0.016	0.013	0	55.9	55	56.8	158	156	0	28	28
2025	4	4	21	23	9	0.879	-0.056	3.13	0.013	0.01	0	56.8	58	48.6	159	163	0	27	28
2025	4	4	21	33	9	0.876	-0.049	3.127	0.02	0.016	0	56.8	58	47.7	159	163	0	27	28
2025	4	4	21	43	9	0.86	-0.026	3.127	0.016	0.013	0	56.3	57.6	43.4	159	163	0	28	29
2025	4	4	21	53	9	0.856	-0.023	3.127	0.013	0.01	0	56.3	58	42.1	159	163	0	28	28
2025	4	4	22	3	9	0.856	-0.066	3.12	0.016	0.013	0	56.8	58	50.7	159	163	0	27	28
2025	4	4	22	13	9	0.843	-0.049	3.12	0.016	0.013	0	56.3	58	55.5	159	163	0	28	28
2025	4	4	22	23	9	0.827	-0.046	3.12	0.016	0.013	0	56.3	58	56.3	159	163	0	28	28
2025	4	4	22	33	9	0.846	-0.052	3.117	0.013	0.01	0	56.3	58.5	58	159	163	0	28	27
2025	4	4	22	43	9	0.866	-0.039	3.117	0.02	0.016	0	56.3	57.6	62.4	159	162	0	28	28
2025	4	4	22	53	9	0.863	-0.013	3.114	0.016	0.013	0	56.3	58	64.9	159	163	0	28	28
2025	4	4	23	3	9	0.86	-0.056	3.11	0.013	0.01	0	56.3	57.6	64.5	159	162	0	28	28
2025	4	4	23	13	9	0.853	-0.069	3.11	0.013	0.01	0	56.8	57.2	61.5	159	162	0	27	29
2025	4	4	23	23	9	0.84	-0.052	3.107	0.016	0.016	0	56.3	57.6	55.5	158	162	0	27	28
2025	4	4	23	33	9	0.823	-0.056	3.104	0.016	0.013	0	56.3	58	45.6	159	163	0	28	28
2025	4	4	23	43	9	0.85	-0.039	3.097	0.013	0.01	0	55.9	57.6	43	158	162	0	28	28
2025	4	4	23	53	9	0.846	-0.052	3.094	0.02	0.016	0	55.9	57.6	49	158	162	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	5	0	3	9	0.856	-0.026	3.087	0.016	0.013	0	55.9	57.6	51.2	158	162	0	28	28
2025	4	5	0	13	9	0.837	-0.062	3.084	0.016	0.013	0	55.9	57.6	60.6	158	162	0	28	28
2025	4	5	0	23	9	0.846	-0.036	3.084	0.016	0.016	0	56.3	57.2	64.1	158	162	0	27	29
2025	4	5	0	33	9	0.85	-0.062	3.081	0.013	0.01	0	55.9	57.6	64.9	158	162	0	28	28
2025	4	5	0	43	9	0.869	-0.056	3.081	0.016	0.013	0	56.3	57.6	65.8	158	162	0	27	28
2025	4	5	0	53	9	0.814	-0.02	3.077	0.016	0.013	0	56.3	57.6	66.2	158	162	0	27	28
2025	4	5	1	3	9	0.873	-0.023	3.077	0.013	0.01	0	55.5	57.6	66.7	157	162	0	28	28
2025	4	5	1	13	9	0.804	-0.046	3.074	0.016	0.013	0	55.5	57.6	66.2	157	162	0	28	28
2025	4	5	1	23	9	0.84	-0.039	3.074	0.016	0.016	0	55.5	57.2	47.3	157	161	0	28	28
2025	4	5	1	33	9	0.83	-0.039	3.071	0.016	0.016	0	55.5	57.2	59.8	157	161	0	28	28
2025	4	5	1	43	9	0.794	-0.007	3.071	0.013	0.01	0	55.5	57.2	63.6	157	161	0	28	28
2025	4	5	1	53	9	0.817	-0.072	3.071	0.016	0.013	0	55.5	57.2	61.5	157	161	0	28	28
2025	4	5	2	3	9	0.84	-0.039	3.068	0.013	0.01	0	55.5	57.2	65.8	157	161	0	28	28
2025	4	5	2	13	9	0.85	-0.062	3.068	0.016	0.013	0	55.5	57.2	62.4	157	161	0	28	28
2025	4	5	2	23	9	0.827	-0.036	3.068	0.016	0.013	0	55.9	57.2	66.2	157	161	0	27	28
2025	4	5	2	33	9	0.823	-0.046	3.064	0.013	0.01	0	55.9	57.2	61.5	157	161	0	27	28
2025	4	5	2	43	9	0.837	-0.069	3.064	0.013	0.01	0	55.5	57.2	55.9	157	161	0	28	28
2025	4	5	2	53	9	0.846	-0.066	3.061	0.013	0.01	0	55.5	56.8	64.5	157	161	0	28	29
2025	4	5	3	3	9	0.81	-0.069	3.061	0.016	0.013	0	55.5	57.2	62.8	157	161	0	28	28
2025	4	5	3	13	9	0.837	-0.023	3.058	0.016	0.013	0	55.5	56.8	62.4	157	161	0	28	29
2025	4	5	3	23	9	0.827	-0.052	3.054	0.016	0.013	0	55.9	57.2	63.6	157	161	0	27	28
2025	4	5	3	33	9	0.807	-0.026	3.051	0.016	0.016	0	55.5	57.2	64.1	157	161	0	28	28
2025	4	5	3	43	9	0.81	-0.052	3.045	0.016	0.013	0	55.9	56.8	63.6	157	161	0	27	29
2025	4	5	3	53	9	0.823	-0.039	3.045	0.016	0.013	0	55.5	56.8	64.5	157	160	0	28	28
2025	4	5	4	3	9	0.85	-0.046	3.041	0.013	0.01	0	55.5	57.2	64.5	157	161	0	28	28
2025	4	5	4	13	9	0.823	-0.056	3.038	0.016	0.016	0	55	56.8	64.9	156	160	0	28	28
2025	4	5	4	23	9	0.81	-0.069	3.038	0.016	0.013	0	55.5	56.8	64.9	157	160	0	28	28
2025	4	5	4	33	9	0.827	-0.052	3.035	0.013	0.01	0	55	56.3	59.8	156	160	0	28	29
2025	4	5	4	43	9	0.82	-0.069	3.035	0.016	0.013	0	55	56.8	46.4	156	160	0	28	28
2025	4	5	4	53	9	0.807	-0.056	3.035	0.016	0.016	0	54.6	56.8	48.6	156	160	0	29	28
2025	4	5	5	3	9	0.801	-0.062	3.035	0.016	0.013	0	55.9	56.8	45.2	157	161	0	27	29
2025	4	5	5	13	9	0.84	-0.069	3.031	0.016	0.016	0	56.3	57.2	51.6	158	162	0	27	29
2025	4	5	5	23	9	0.837	-0.069	3.031	0.016	0.013	0	55.9	57.6	58	158	162	0	28	28
2025	4	5	5	33	9	0.81	-0.039	3.031	0.016	0.013	0	55.9	57.2	46.9	158	162	0	28	29
2025	4	5	5	43	9	0.814	-0.039	3.031	0.016	0.016	0	55.9	57.2	46.9	158	162	0	28	29
2025	4	5	5	53	9	0.86	-0.036	3.031	0.016	0.013	0	55.5	56.8	45.2	157	161	0	28	29
2025	4	5	6	3	9	0.797	-0.046	3.028	0.016	0.013	0	55.9	57.2	42.6	158	162	0	28	29
2025	4	5	6	13	9	0.81	-0.036	3.028	0.016	0.013	0	55.5	57.2	43.9	157	162	0	28	29
2025	4	5	6	23	9	0.837	-0.049	3.028	0.016	0.013	0	55.9	56.8	44.7	157	161	0	27	29
2025	4	5	6	33	9	0.82	-0.059	3.028	0.016	0.013	0	55.9	57.2	43	158	162	0	28	29
2025	4	5	6	43	9	0.791	0	3.025	0.013	0.01	0	55.9	57.6	41.7	158	162	0	28	28
2025	4	5	6	53	9	0.837	-0.039	3.025	0.016	0.016	0	55.9	57.6	42.6	158	162	0	28	28
2025	4	5	7	3	9	0.794	-0.023	3.025	0.02	0.016	0	56.3	57.2	42.1	158	162	0	27	29
2025	4	5	7	13	9	0.817	-0.052	3.025	0.016	0.016	0	55.9	57.2	42.6	158	162	0	28	29
2025	4	5	7	23	9	0.774	-0.079	3.022	0.016	0.013	0	56.3	57.6	40	159	162	0	28	28
2025	4	5	7	33	9	0.778	-0.049	3.022	0.016	0.016	0	55.5	57.2	41.7	157	162	0	28	29
2025	4	5	7	43	9	0.768	-0.056	3.022	0.016	0.013	0	55.9	57.6	43	158	162	0	28	28
2025	4	5	7	53	9	0.82	-0.049	3.022	0.016	0.013	0	55	56.8	42.1	157	161	0	29	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	5	8	3	9	0.823	-0.089	3.018	0.016	0.016	0	55	56.8	43	157	161	0	29	29
2025	4	5	8	13	9	0.781	-0.095	3.018	0.016	0.013	0	55.5	56.8	42.6	157	161	0	28	29
2025	4	5	8	23	9	0.84	-0.056	3.018	0.013	0.01	0	55.5	56.8	41.7	157	161	0	28	29
2025	4	5	8	33	9	0.823	-0.056	3.015	0.016	0.016	0	55.5	57.2	41.3	157	161	0	28	28
2025	4	5	8	43	9	0.787	-0.049	3.018	0.016	0.013	0	55.9	57.2	40.9	158	161	0	28	28
2025	4	5	8	53	9	0.778	-0.075	3.012	0.016	0.016	0	55.9	57.2	43	158	161	0	28	28
2025	4	5	9	3	9	0.801	-0.059	3.012	0.016	0.016	0	55.9	57.6	43	158	162	0	28	28
2025	4	5	9	13	9	0.781	-0.03	3.009	0.016	0.013	0	55.5	57.2	42.1	157	161	0	28	28
2025	4	5	9	23	9	0.784	-0.059	3.009	0.013	0.01	0	55.5	57.2	42.6	157	161	0	28	28
2025	4	5	9	33	9	0.787	-0.059	3.012	0.016	0.013	0	55	56.8	42.6	157	161	0	29	29
2025	4	5	9	43	9	0.771	-0.056	3.009	0.02	0.016	0	55.9	56.8	42.1	158	161	0	28	29
2025	4	5	9	53	9	0.768	-0.043	3.009	0.016	0.013	0	55.9	56.3	42.6	158	161	0	28	30
2025	4	5	10	3	9	0.81	-0.059	3.005	0.02	0.016	0	55.5	57.2	43.4	157	161	0	28	28
2025	4	5	10	13	9	0.843	-0.059	3.009	0.016	0.016	0	55.5	57.2	42.6	157	161	0	28	28
2025	4	5	10	23	9	0.807	-0.043	3.005	0.016	0.013	0	55.5	57.6	43.4	157	162	0	28	28
2025	4	5	10	33	9	0.837	-0.013	3.005	0.016	0.013	0	55.5	56.8	43.9	157	161	0	28	29
2025	4	5	10	43	9	0.787	-0.089	3.005	0.016	0.013	0	55.9	57.6	44.7	157	162	0	27	28
2025	4	5	10	53	9	0.804	-0.056	3.005	0.016	0.016	0	55.5	56.8	44.3	157	161	0	28	29
2025	4	5	11	3	9	0.758	-0.043	3.005	0.013	0.01	0	55.9	57.2	45.2	158	162	0	28	29
2025	4	5	11	13	9	0.787	-0.026	3.005	0.016	0.016	0	55.9	57.6	46	157	162	0	27	28
2025	4	5	11	23	9	0.768	-0.069	3.005	0.016	0.013	0	55.5	57.2	46.9	157	161	0	28	28
2025	4	5	11	33	9	0.807	-0.075	3.005	0.013	0.01	0	56.3	57.6	45.6	158	162	0	27	28
2025	4	5	11	43	9	0.807	-0.066	3.005	0.016	0.013	0	55.9	57.2	45.6	157	162	0	27	29
2025	4	5	11	53	9	0.794	-0.062	3.005	0.016	0.013	0	55.5	57.2	45.2	157	162	0	28	29
2025	4	5	12	3	9	0.823	-0.039	3.005	0.016	0.013	0	55.5	57.6	43.9	157	162	0	28	28
2025	4	5	12	13	9	0.804	-0.072	3.005	0.016	0.013	0	56.3	58	51.6	158	162	0	27	27
2025	4	5	12	23	9	0.827	-0.052	3.002	0.016	0.013	0	55.9	57.6	44.3	158	162	0	28	28
2025	4	5	12	33	9	0.784	-0.062	3.005	0.016	0.016	0	55.9	58	61.1	158	163	0	28	28
2025	4	5	12	43	9	0.807	-0.062	3.002	0.016	0.016	0	57.2	57.6	53.3	160	162	0	27	28
2025	4	5	12	53	9	0.814	-0.052	3.002	0.016	0.013	0	57.2	58	58	160	163	0	27	28
2025	4	5	13	3	9	0.791	-0.023	2.999	0.016	0.016	0	57.2	58	43	160	163	0	27	28
2025	4	5	13	13	9	0.801	-0.039	2.999	0.013	0.01	0	57.2	58	51.2	160	163	0	27	28
2025	4	5	13	23	9	0.764	-0.043	2.999	0.016	0.013	0	57.2	58	63.6	160	163	0	27	28
2025	4	5	13	33	9	0.761	-0.036	2.995	0.016	0.016	0	56.8	58	61.5	160	163	0	28	28
2025	4	5	13	43	9	0.781	-0.03	2.995	0.016	0.016	0	56.8	58	50.7	160	163	0	28	28
2025	4	5	13	53	9	0.807	-0.03	2.992	0.016	0.016	0	56.8	58	52.9	160	163	0	28	28
2025	4	5	14	3	9	0.797	-0.046	2.992	0.013	0.01	0	56.8	58	63.6	160	163	0	28	28
2025	4	5	14	13	9	0.791	-0.049	2.992	0.016	0.013	0	57.2	58	60.6	160	162	0	27	27
2025	4	5	14	23	9	0.784	-0.052	2.992	0.016	0.016	0	57.2	58	65.4	160	163	0	27	28
2025	4	5	14	33	9	0.784	-0.069	2.992	0.016	0.013	0	57.2	58	48.2	160	163	0	27	28
2025	4	5	14	43	9	0.82	-0.052	2.992	0.013	0.01	0	57.2	58.9	61.9	160	163	0	27	26
2025	4	5	14	53	9	0.778	-0.026	2.992	0.016	0.016	0	57.2	58	61.1	160	163	0	27	28
2025	4	5	15	3	9	0.84	-0.075	2.992	0.013	0.01	0	57.2	58.5	59.3	160	163	0	27	27
2025	4	5	15	13	9	0.797	-0.007	2.992	0.016	0.013	0	57.6	58.5	56.8	161	163	0	27	27
2025	4	5	15	23	9	0.771	-0.049	2.992	0.016	0.013	0	57.2	58	64.1	160	163	0	27	28
2025	4	5	15	33	9	0.774	-0.059	2.992	0.016	0.013	0	56.8	58.5	46.9	160	163	0	28	27
2025	4	5	15	43	9	0.791	-0.049	2.992	0.013	0.01	0	57.6	58.5	61.5	161	164	0	27	28
2025	4	5	15	53	9	0.804	-0.007	2.992	0.016	0.013	0	57.2	58.5	49.5	160	164	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	5	16	3	9	0.791	-0.026	2.992	0.013	0.01	0	57.6	58.5	45.2	161	164	0	27	28
2025	4	5	16	13	9	0.768	0	2.992	0.016	0.016	0	57.6	58.5	65.8	161	164	0	27	28
2025	4	5	16	23	9	0.833	-0.02	2.992	0.013	0.01	0	57.2	58.5	54.6	161	164	0	28	28
2025	4	5	16	33	9	0.83	-0.066	2.992	0.016	0.013	0	57.2	58	64.1	160	163	0	27	28
2025	4	5	16	43	9	0.764	-0.059	2.992	0.016	0.016	0	57.6	58.5	65.8	161	164	0	27	28
2025	4	5	16	53	9	0.758	-0.092	2.992	0.016	0.013	0	57.2	58.5	67.1	161	164	0	28	28
2025	4	5	17	3	9	0.81	-0.036	2.992	0.02	0.016	0	56.8	58.5	61.1	159	163	0	27	27
2025	4	5	17	13	9	0.807	-0.043	2.992	0.016	0.013	0	56.8	58	65.8	159	163	0	27	28
2025	4	5	17	23	9	0.827	-0.043	2.992	0.016	0.013	0	57.2	58	67.5	160	163	0	27	28
2025	4	5	17	33	9	0.804	-0.039	2.992	0.016	0.013	0	57.2	58.9	67.5	160	164	0	27	27
2025	4	5	17	43	9	0.807	-0.056	2.992	0.016	0.013	0	56.8	58	67.1	159	163	0	27	28
2025	4	5	17	53	9	0.817	-0.043	2.992	0.016	0.016	0	56.8	58.5	67.5	159	163	0	27	27
2025	4	5	18	3	9	0.784	-0.046	2.992	0.016	0.013	0	56.8	58	66.7	159	163	0	27	28
2025	4	5	18	13	9	0.774	-0.016	2.992	0.016	0.016	0	56.8	58	67.9	159	163	0	27	28
2025	4	5	18	23	9	0.807	-0.072	2.992	0.016	0.013	0	56.8	58.5	67.9	159	163	0	27	27
2025	4	5	18	33	9	0.732	0	2.992	0.016	0.013	0	57.2	58.9	66.7	160	164	0	27	27
2025	4	5	18	43	9	0.764	-0.016	2.992	0.016	0.013	0	57.2	58	67.1	160	163	0	27	28
2025	4	5	18	53	9	0.807	-0.043	2.989	0.016	0.013	0	57.2	58.9	50.3	160	164	0	27	27
2025	4	5	19	3	9	0.82	-0.079	2.989	0.016	0.016	0	57.2	58.9	67.5	160	164	0	27	27
2025	4	5	19	13	9	0.761	-0.043	2.989	0.016	0.013	0	56.8	58.9	67.1	160	164	0	28	27
2025	4	5	19	23	9	0.797	-0.016	2.989	0.016	0.016	0	57.2	58.9	67.5	160	164	0	27	27
2025	4	5	19	33	9	0.771	-0.049	2.989	0.016	0.013	0	57.2	58.5	67.5	160	163	0	27	27
2025	4	5	19	43	9	0.768	-0.069	2.989	0.016	0.013	0	57.6	58.5	67.1	160	164	0	26	28
2025	4	5	19	53	9	0.784	-0.043	2.989	0.013	0.01	0	57.2	58.9	66.7	160	164	0	27	27
2025	4	5	20	3	9	0.827	-0.026	2.989	0.016	0.013	0	57.2	58.9	67.1	160	164	0	27	27
2025	4	5	20	13	9	0.797	-0.049	2.989	0.016	0.013	0	57.2	58.5	67.5	160	163	0	27	27
2025	4	5	20	23	9	0.817	-0.046	2.986	0.013	0.01	0	57.2	58.5	67.9	160	164	0	27	28
2025	4	5	20	33	9	0.781	-0.039	2.986	0.016	0.013	0	57.2	58.5	66.7	160	164	0	27	28
2025	4	5	20	43	9	0.761	-0.062	2.986	0.016	0.013	0	57.2	58.9	64.5	160	164	0	27	27
2025	4	5	20	53	9	0.82	-0.036	2.986	0.016	0.013	0	57.6	58.5	67.1	160	163	0	26	27
2025	4	5	21	3	9	0.797	-0.056	2.986	0.013	0.01	0	56.8	58.5	67.5	160	164	0	28	28
2025	4	5	21	13	9	0.807	-0.016	2.986	0.02	0.016	0	57.2	58	67.5	160	163	0	27	28
2025	4	5	21	23	9	0.784	-0.013	2.986	0.016	0.013	0	57.2	58	67.5	160	163	0	27	28
2025	4	5	21	33	9	0.751	-0.052	2.982	0.016	0.013	0	57.2	58	67.5	160	163	0	27	28
2025	4	5	21	43	9	0.804	-0.013	2.982	0.016	0.016	0	56.8	58	67.9	159	163	0	27	28
2025	4	5	21	53	9	0.794	-0.043	2.982	0.016	0.016	0	57.2	58	67.9	160	163	0	27	28
2025	4	5	22	3	9	0.791	-0.039	2.982	0.016	0.016	0	56.8	58	67.5	160	163	0	28	28
2025	4	5	22	13	9	0.781	-0.049	2.982	0.016	0.016	0	56.8	58	67.5	159	163	0	27	28
2025	4	5	22	23	9	0.761	-0.056	2.979	0.013	0.01	0	57.2	58	67.1	160	163	0	27	28
2025	4	5	22	33	9	0.801	-0.049	2.982	0.016	0.013	0	56.3	58	67.9	159	163	0	28	28
2025	4	5	22	43	9	0.797	-0.056	2.979	0.02	0.016	0	56.8	58	67.5	159	163	0	27	28
2025	4	5	22	53	9	0.771	-0.069	2.979	0.013	0.01	0	56.3	58.5	67.9	158	163	0	27	27
2025	4	5	23	3	9	0.787	-0.056	2.979	0.016	0.013	0	56.3	58	67.9	159	163	0	28	28
2025	4	5	23	13	9	0.771	-0.052	2.979	0.016	0.016	0	57.2	58	67.5	159	163	0	26	28
2025	4	5	23	23	9	0.791	-0.062	2.979	0.016	0.013	0	56.8	58	67.5	159	163	0	27	28
2025	4	5	23	33	9	0.768	-0.03	2.979	0.016	0.016	0	56.3	58	67.5	159	163	0	28	28
2025	4	5	23	43	9	0.771	-0.059	2.976	0.02	0.016	0	55.9	57.6	67.5	158	163	0	28	29
2025	4	5	23	53	9	0.768	-0.059	2.976	0.016	0.013	0	56.8	58	67.5	159	163	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	6	0	3	9	0.804	-0.049	2.976	0.02	0.016	0	56.3	58	67.5	159	163	0	28	28
2025	4	6	0	13	9	0.748	-0.059	2.976	0.016	0.016	0	56.3	58	67.9	158	163	0	27	28
2025	4	6	0	23	9	0.774	-0.052	2.976	0.016	0.013	0	55.9	57.6	67.5	158	162	0	28	28
2025	4	6	0	33	9	0.781	-0.03	2.976	0.016	0.016	0	56.3	57.6	67.5	158	162	0	27	28
2025	4	6	0	43	9	0.764	-0.069	2.976	0.016	0.013	0	55.9	57.6	67.9	158	163	0	28	29
2025	4	6	0	53	9	0.778	-0.072	2.972	0.016	0.013	0	55.9	58	67.5	158	163	0	28	28
2025	4	6	1	3	9	0.817	-0.046	2.972	0.013	0.01	0	55.9	57.6	67.5	158	162	0	28	28
2025	4	6	1	13	9	0.814	-0.072	2.972	0.013	0.01	0	55.9	57.2	67.9	158	162	0	28	29
2025	4	6	1	23	9	0.774	-0.069	2.972	0.016	0.013	0	55.9	57.6	67.5	158	162	0	28	28
2025	4	6	1	33	9	0.781	-0.043	2.972	0.016	0.013	0	55.9	57.6	67.5	158	162	0	28	28
2025	4	6	1	43	9	0.781	-0.039	2.972	0.016	0.016	0	56.3	57.6	67.1	158	162	0	27	28
2025	4	6	1	53	9	0.817	-0.043	2.972	0.016	0.013	0	56.3	57.6	67.5	158	162	0	27	28
2025	4	6	2	3	9	0.778	-0.046	2.969	0.02	0.016	0	55.9	57.6	67.5	158	162	0	28	28
2025	4	6	2	13	9	0.781	-0.039	2.969	0.016	0.013	0	55.9	57.2	67.5	158	162	0	28	29
2025	4	6	2	23	9	0.758	-0.023	2.969	0.013	0.01	0	55.9	57.6	67.5	158	162	0	28	28
2025	4	6	2	33	9	0.781	-0.102	2.969	0.016	0.013	0	55.5	57.6	67.9	157	162	0	28	28
2025	4	6	2	43	9	0.774	-0.03	2.969	0.016	0.013	0	56.3	57.6	67.9	158	162	0	27	28
2025	4	6	2	53	9	0.787	-0.069	2.969	0.016	0.016	0	55.5	57.6	67.5	157	162	0	28	28
2025	4	6	3	3	9	0.817	-0.043	2.969	0.02	0.016	0	55.9	57.2	67.5	157	161	0	27	28
2025	4	6	3	13	9	0.791	-0.059	2.969	0.016	0.013	0	55.9	57.6	67.5	157	162	0	27	28
2025	4	6	3	23	9	0.758	-0.082	2.966	0.016	0.013	0	55.5	57.2	67.5	157	161	0	28	28
2025	4	6	3	33	9	0.781	-0.075	2.969	0.016	0.013	0	55.5	57.2	67.9	157	161	0	28	28
2025	4	6	3	43	9	0.741	-0.066	2.966	0.013	0.01	0	55.9	57.2	67.1	158	162	0	28	29
2025	4	6	3	53	9	0.761	-0.043	2.966	0.016	0.016	0	55.5	57.2	67.5	157	161	0	28	28
2025	4	6	4	3	9	0.853	-0.066	2.966	0.016	0.016	0	55.9	57.2	67.5	157	161	0	27	28
2025	4	6	4	13	9	0.801	-0.056	2.966	0.016	0.013	0	55.9	56.8	67.1	157	161	0	27	29
2025	4	6	4	23	9	0.748	-0.056	2.966	0.016	0.016	0	55.5	57.2	67.5	157	161	0	28	28
2025	4	6	4	33	9	0.768	-0.056	2.966	0.016	0.016	0	55.5	56.8	67.5	157	161	0	28	29
2025	4	6	4	43	9	0.755	-0.069	2.966	0.016	0.013	0	55.5	57.2	67.1	157	161	0	28	28
2025	4	6	4	53	9	0.794	-0.036	2.966	0.013	0.01	0	55.5	56.3	67.1	157	160	0	28	29
2025	4	6	5	3	9	0.791	-0.033	2.966	0.016	0.013	0	55.5	56.8	67.1	157	161	0	28	29
2025	4	6	5	13	9	0.797	-0.043	2.966	0.013	0.01	0	55.5	57.6	67.5	157	162	0	28	28
2025	4	6	5	23	9	0.768	-0.056	2.966	0.016	0.013	0	55.9	57.2	66.7	157	162	0	27	29
2025	4	6	5	33	9	0.781	-0.072	2.966	0.02	0.016	0	55.5	57.2	67.5	157	161	0	28	28
2025	4	6	5	43	9	0.758	-0.059	2.963	0.016	0.013	0	55.5	56.8	66.7	157	161	0	28	29
2025	4	6	5	53	9	0.801	-0.056	2.963	0.016	0.013	0	55.5	57.2	67.5	157	161	0	28	28
2025	4	6	6	3	9	0.778	-0.036	2.963	0.02	0.016	0	55.5	56.8	67.1	157	161	0	28	29
2025	4	6	6	13	9	0.797	-0.095	2.963	0.016	0.013	0	55.5	56.8	67.5	156	161	0	27	29
2025	4	6	6	23	9	0.748	-0.069	2.963	0.016	0.016	0	55.5	57.2	67.5	157	161	0	28	28
2025	4	6	6	33	9	0.768	-0.043	2.963	0.016	0.016	0	55.9	57.2	67.1	157	161	0	27	28
2025	4	6	6	43	9	0.787	-0.066	2.963	0.016	0.013	0	55.5	57.2	67.5	157	161	0	28	28
2025	4	6	6	53	9	0.755	-0.085	2.963	0.016	0.013	0	55.5	57.2	67.1	157	161	0	28	28
2025	4	6	7	3	9	0.814	-0.075	2.963	0.016	0.013	0	55	57.2	67.9	156	161	0	28	28
2025	4	6	7	13	9	0.787	-0.072	2.963	0.016	0.016	0	55.5	57.2	67.9	156	161	0	27	28
2025	4	6	7	23	9	0.82	-0.033	2.963	0.016	0.016	0	55.5	57.2	67.5	156	161	0	27	28
2025	4	6	7	33	9	0.794	-0.056	2.963	0.013	0.01	0	55	56.8	67.5	156	160	0	28	28
2025	4	6	7	43	9	0.755	-0.046	2.963	0.016	0.013	0	55.5	57.2	67.5	157	161	0	28	28
2025	4	6	7	53	9	0.787	-0.039	2.963	0.013	0.01	0	55	56.8	67.9	156	160	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	6	8	3	9	0.797	-0.046	2.963	0.016	0.016	0	55	56.8	67.5	156	160	0	28	28
2025	4	6	8	13	9	0.774	-0.039	2.963	0.016	0.013	0	54.6	56.8	68.4	155	160	0	28	28
2025	4	6	8	23	9	0.778	-0.066	2.963	0.013	0.01	0	55.5	56.8	67.9	156	160	0	27	28
2025	4	6	8	33	9	0.827	-0.075	2.963	0.016	0.016	0	54.6	56.8	68.4	155	160	0	28	28
2025	4	6	8	43	9	0.791	-0.056	2.963	0.02	0.016	0	54.6	56.3	68.8	155	160	0	28	29
2025	4	6	8	53	9	0.791	-0.043	2.963	0.016	0.013	0	54.6	56.3	68.8	155	160	0	28	29
2025	4	6	9	3	9	0.781	-0.052	2.963	0.016	0.013	0	54.6	56.8	68.4	155	160	0	28	28
2025	4	6	9	13	9	0.81	-0.033	2.963	0.013	0.01	0	54.6	56.3	69.2	155	159	0	28	28
2025	4	6	9	23	9	0.745	-0.052	2.963	0.016	0.013	0	54.2	56.3	67.9	154	159	0	28	28
2025	4	6	9	33	9	0.764	-0.033	2.963	0.016	0.013	0	54.2	56.3	64.9	154	159	0	28	28
2025	4	6	9	43	9	0.784	-0.023	2.966	0.016	0.013	0	54.6	55.9	69.7	155	159	0	28	29
2025	4	6	9	53	9	0.774	-0.039	2.966	0.016	0.013	0	54.2	56.3	67.1	154	159	0	28	28
2025	4	6	10	3	9	0.784	-0.036	2.966	0.016	0.016	0	54.2	56.3	67.1	154	159	0	28	28
2025	4	6	10	13	9	0.791	-0.043	2.966	0.016	0.016	0	54.6	56.3	56.8	154	159	0	27	28
2025	4	6	10	23	9	0.778	-0.079	2.966	0.016	0.013	0	54.6	56.3	59.8	155	159	0	28	28
2025	4	6	10	33	9	0.787	-0.066	2.966	0.016	0.013	0	54.6	55.9	59.3	154	158	0	27	28
2025	4	6	10	43	9	0.778	-0.033	2.966	0.016	0.016	0	54.2	55.9	61.1	154	158	0	28	28
2025	4	6	10	53	9	0.797	-0.023	2.966	0.02	0.016	0	54.6	55.9	47.3	154	158	0	27	28
2025	4	6	11	3	9	0.791	-0.056	2.966	0.016	0.013	0	55	55.9	49.9	155	159	0	27	29
2025	4	6	11	13	9	0.735	-0.039	2.966	0.016	0.013	0	54.6	56.3	53.8	155	159	0	28	28
2025	4	6	11	23	9	0.774	-0.03	2.966	0.016	0.016	0	54.6	56.3	52.9	155	159	0	28	28
2025	4	6	11	33	9	0.807	-0.062	2.966	0.02	0.016	0	54.2	56.3	48.2	154	159	0	28	28
2025	4	6	11	43	9	0.781	-0.069	2.966	0.02	0.016	0	55	56.3	50.7	155	159	0	27	28
2025	4	6	11	53	9	0.787	-0.043	2.963	0.016	0.013	0	55	56.3	43	155	159	0	27	28
2025	4	6	12	3	9	0.768	-0.013	2.963	0.016	0.016	0	54.6	56.8	42.1	155	159	0	28	27
2025	4	6	12	13	9	0.827	-0.033	2.963	0.02	0.016	0	55	57.2	40.4	155	160	0	27	27
2025	4	6	12	23	9	0.778	-0.066	2.959	0.013	0.01	0	55	56.3	42.6	155	159	0	27	28
2025	4	6	12	33	9	0.784	-0.033	2.959	0.016	0.013	0	54.6	56.8	46.9	155	159	0	28	27
2025	4	6	12	43	9	0.764	-0.043	2.959	0.016	0.016	0	54.6	56.8	42.1	155	160	0	28	28
2025	4	6	12	53	9	0.827	-0.016	2.956	0.016	0.013	0	55	56.8	45.6	155	160	0	27	28
2025	4	6	13	3	9	0.814	-0.02	2.959	0.013	0.01	0	55	56.3	42.1	155	159	0	27	28
2025	4	6	13	13	9	0.741	-0.03	2.959	0.016	0.013	0	55.9	57.2	42.6	157	160	0	27	27
2025	4	6	13	23	9	0.768	-0.046	2.959	0.016	0.013	0	55.5	56.8	40	157	160	0	28	28
2025	4	6	13	33	9	0.761	-0.046	2.959	0.016	0.013	0	55.9	56.8	42.1	157	160	0	27	28
2025	4	6	13	43	9	0.804	-0.052	2.959	0.016	0.013	0	55.9	56.8	40.9	157	160	0	27	28
2025	4	6	13	53	9	0.791	-0.023	2.959	0.016	0.013	0	55.9	57.6	43.9	158	161	0	28	27
2025	4	6	14	3	9	0.748	-0.049	2.959	0.016	0.013	0	55.9	56.8	54.6	157	160	0	27	28
2025	4	6	14	13	9	0.778	-0.046	2.959	0.016	0.013	0	55.9	57.6	42.1	157	161	0	27	27
2025	4	6	14	23	9	0.741	-0.046	2.959	0.016	0.013	0	55.5	57.2	41.3	156	160	0	27	27
2025	4	6	14	33	9	0.791	-0.036	2.959	0.016	0.016	0	55.9	57.6	43.4	157	161	0	27	27
2025	4	6	14	43	9	0.764	-0.036	2.956	0.016	0.013	0	55.5	57.2	43.4	157	160	0	28	27
2025	4	6	14	53	9	0.794	-0.085	2.959	0.016	0.013	0	55.9	57.2	41.3	157	160	0	27	27
2025	4	6	15	3	9	0.794	-0.056	2.959	0.016	0.013	0	55.9	57.2	44.3	157	161	0	27	28
2025	4	6	15	13	9	0.84	-0.062	2.959	0.016	0.013	0	55.9	56.8	40.4	157	160	0	27	28
2025	4	6	15	23	9	0.778	-0.049	2.959	0.016	0.013	0	55.9	57.6	41.7	157	161	0	27	27
2025	4	6	15	33	9	0.768	-0.016	2.959	0.016	0.013	0	55.5	57.2	40	157	161	0	28	28
2025	4	6	15	43	9	0.801	-0.043	2.959	0.02	0.016	0	56.3	57.2	45.2	158	161	0	27	28
2025	4	6	15	53	9	0.794	-0.013	2.959	0.016	0.016	0	56.8	57.2	41.7	158	161	0	26	28

Mazourka (0354)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	
2025	4	6	16	3	9	0.771	-0.066	2.959	0.016	0.013	0	56.8	57.6	41.3	159	162	0	27	28	
2025	4	6	16	13	9	0.794	-0.039	2.959	0.016	0.016	0	56.3	57.2	41.3	158	161	0	27	28	
2025	4	6	16	23	9	0.787	-0.049	2.959	0.016	0.016	0	56.8	58	42.1	159	162	0	27	27	
2025	4	6	16	33	9	0.784	-0.052	2.959	0.016	0.016	0	56.3	57.6	41.3	158	161	0	27	27	
2025	4	6	16	43	9	0.797	-0.043	2.959	0.016	0.013	0	56.3	57.6	41.7	158	161	0	27	27	
2025	4	6	16	53	9	0.81	-0.049	2.959	0.016	0.013	0	56.3	57.2	44.3	158	161	0	27	28	
2025	4	6	17	3	9	0.758	-0.003	2.959	0.016	0.016	0	55.9	57.2	46.4	157	161	0	27	28	
2025	4	6	17	13	9	0.797	-0.069	2.959	0.016	0.013	0	56.3	56.8	46.4	157	160	0	26	28	
2025	4	6	17	23	9	0.797	-0.036	2.959	0.016	0.013	0	56.3	57.2	52	158	161	0	27	28	
2025	4	6	17	33	9	0.784	-0.046	2.959	0.013	0.01	0	55.9	57.2	54.2	157	160	0	27	27	
2025	4	6	17	43	9	0.778	-0.023	2.959	0.016	0.016	0	56.3	57.2	65.4	158	161	0	27	28	
2025	4	6	17	53	9	0.755	-0.02	2.959	0.013	0.01	0	56.3	57.2	67.9	158	161	0	27	28	
2025	4	6	18	3	9	0.751	-0.033	2.959	0.016	0.016	0	56.3	57.6	67.5	158	161	0	27	27	
2025	4	6	18	13	9	0.751	-0.046	2.959	0.016	0.013	0	56.3	58	67.9	158	162	0	27	27	
2025	4	6	18	23	9	0.761	-0.033	2.959	0.016	0.013	0	55.9	57.6	68.4	158	161	0	28	27	
2025	4	6	18	33	9	0.774	-0.075	2.959	0.016	0.016	0	56.3	57.6	68.4	158	161	0	27	27	
2025	4	6	18	43	9	0.814	-0.059	2.959	0.016	0.013	0	56.3	57.6	67.9	158	161	0	27	27	
2025	4	6	18	53	9	0.814	-0.052	2.959	0.016	0.013	0	56.8	57.6	67.9	158	161	0	26	27	
2025	4	6	19	3	9	0.784	-0.039	2.959	0.016	0.013	0	56.3	57.6	67.9	158	162	0	27	28	
2025	4	6	19	13	9	0.797	-0.052	2.956	0.016	0.013	0	56.8	58.5	67.5	159	163	0	27	27	
2025	4	6	19	23	9	0.764	-0.043	2.956	0.016	0.013	0	56.8	58.5	67.1	159	163	0	27	27	
2025	4	6	19	33	9	0.797	0	2.956	0.016	0.013	0	56.3	57.6	67.9	158	161	0	27	27	
2025	4	6	19	43	9	0.761	-0.039	2.956	0.016	0.013	0	56.8	57.6	67.9	159	162	0	27	28	
2025	4	6	19	53	9	0.797	-0.03	2.956	0.016	0.013	0	56.3	58	67.5	158	162	0	27	27	
2025	4	6	20	3	9	0.804	-0.033	2.956	0.013	0.01	0	56.3	57.6	67.5	158	162	0	27	28	
2025	4	6	20	13	9	0.755	-0.039	2.956	0.016	0.013	0	56.8	58	67.5	159	162	0	27	27	
2025	4	6	20	23	9	0.771	0	2.956	0.016	0.013	0	56.3	58	67.5	158	162	0	27	27	
2025	4	6	20	33	9	0.735	-0.075	2.956	0.016	0.016	0	56.8	58	67.1	159	162	0	27	27	
2025	4	6	20	43	9	0.817	-0.069	2.956	0.016	0.016	0	56.3	58	67.5	158	162	0	27	27	
2025	4	6	20	53	9	0.761	-0.016	2.956	0.016	0.013	0	56.8	58	67.5	159	162	0	27	27	
2025	4	6	21	3	9	0.751	-0.03	2.953	0.013	0.01	0	56.3	57.6	67.9	158	161	0	27	27	
2025	4	6	21	13	9	0.797	-0.082	2.953	0.016	0.013	0	56.8	58	67.5	159	162	0	27	27	
2025	4	6	21	23	9	0.771	-0.049	2.953	0.016	0.013	0	56.3	58	67.5	159	162	0	28	27	
2025	4	6	21	33	9	0.787	-0.059	2.953	0.016	0.013	0	56.8	58	67.9	159	162	0	27	27	
2025	4	6	21	43	9	0.804	-0.036	2.953	0.016	0.013	0	55.9	57.6	67.5	158	162	0	28	28	
2025	4	6	21	53	9	0.778	-0.043	2.953	0.01	0.007	0	56.8	58	67.5	159	162	0	27	27	
2025	4	6	22	3	9	0.758	-0.043	2.953	0.013	0.01	0	56.8	57.6	67.9	159	162	0	27	28	
2025	4	6	22	13	9	0.778	-0.052	2.953	0.013	0.01	0	56.3	57.6	67.1	159	162	0	28	28	
2025	4	6	22	23	9	0.781	-0.049	2.949	0.016	0.016	0	56.8	57.6	67.1	159	162	0	27	28	
2025	4	6	22	33	9	0.741	-0.075	2.949	0.016	0.016	0	57.2	57.6	67.5	159	162	0	26	28	
2025	4	6	22	43	9	0.761	-0.052	2.949	0.016	0.016	0	56.8	58.5	67.1	159	163	0	27	27	
2025	4	6	22	53	9	0.761	-0.043	2.949	0.016	0.013	0	57.2	58.5	67.1	160	163	0	27	27	
2025	4	6	23	3	9	0.768	-0.069	2.949	0.016	0.016	0	56.8	57.6	66.7	159	162	0	27	28	
2025	4	6	23	13	9	0.725	-0.039	2.949	0.016	0.016	0	56.8	57.6	67.1	159	162	0	27	28	
2025	4	6	23	23	9	0.787	-0.036	2.949	0.016	0.013	0	56.8	58	67.1	159	162	0	27	27	
2025	4	6	23	33	9	0.781	-0.072	2.949	0.016	0.013	0	56.3	57.6	67.1	158	162	0	27	28	
2025	4	6	23	43	9	0.784	-0.049	2.946	0.016	0.016	0	56.3	58	67.1	158	162	0	27	27	
2025	4	6	23	53	9	0.735	-0.049	2.946	0.016	0.013	0	56.8	57.6	67.1	159	162	0	27	28	

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	7	0	3	9	0.764	-0.013	2.946	0.016	0.013	0	56.8	57.6	66.7	159	162	0	27	28
2025	4	7	0	13	9	0.761	-0.085	2.946	0.016	0.013	0	55.9	57.6	66.7	158	162	0	28	28
2025	4	7	0	23	9	0.751	-0.039	2.946	0.013	0.01	0	56.8	57.6	66.7	159	162	0	27	28
2025	4	7	0	33	9	0.761	-0.03	2.946	0.016	0.013	0	55.9	57.6	67.1	158	162	0	28	28
2025	4	7	0	43	9	0.82	-0.043	2.946	0.016	0.013	0	56.3	57.2	67.1	158	161	0	27	28
2025	4	7	0	53	9	0.801	-0.023	2.946	0.016	0.013	0	55.9	58	66.7	158	162	0	28	27
2025	4	7	1	3	9	0.755	-0.01	2.946	0.016	0.016	0	56.3	57.2	66.7	158	161	0	27	28
2025	4	7	1	13	9	0.745	-0.075	2.946	0.02	0.016	0	55.9	57.2	67.1	158	161	0	28	28
2025	4	7	1	23	9	0.774	-0.052	2.946	0.016	0.016	0	56.3	57.6	67.1	158	161	0	27	27
2025	4	7	1	33	9	0.778	-0.023	2.946	0.016	0.013	0	56.3	57.2	67.1	158	161	0	27	28
2025	4	7	1	43	9	0.774	-0.069	2.943	0.013	0.01	0	55.5	57.6	66.7	157	161	0	28	27
2025	4	7	1	53	9	0.741	-0.033	2.943	0.01	0.007	0	56.3	58	66.2	158	162	0	27	27
2025	4	7	2	3	9	0.758	-0.069	2.943	0.016	0.013	0	55.5	57.2	67.1	157	161	0	28	28
2025	4	7	2	13	9	0.738	-0.062	2.943	0.016	0.013	0	55.5	57.2	67.1	157	161	0	28	28
2025	4	7	2	23	9	0.768	-0.03	2.943	0.016	0.016	0	55.5	57.2	66.7	157	161	0	28	28
2025	4	7	2	33	9	0.814	-0.03	2.943	0.016	0.013	0	55.9	56.8	66.7	157	160	0	27	28
2025	4	7	2	43	9	0.804	-0.075	2.943	0.016	0.016	0	55.9	57.6	66.7	157	161	0	27	27
2025	4	7	2	53	9	0.794	-0.072	2.943	0.016	0.016	0	55.9	57.2	65.8	158	161	0	28	28
2025	4	7	3	3	9	0.781	-0.056	2.943	0.016	0.013	0	55.9	57.2	66.7	157	161	0	27	28
2025	4	7	3	13	9	0.781	-0.066	2.943	0.016	0.016	0	55.9	56.8	66.7	157	160	0	27	28
2025	4	7	3	23	9	0.791	-0.046	2.943	0.016	0.016	0	55.5	56.8	66.2	157	160	0	28	28
2025	4	7	3	33	9	0.787	-0.082	2.943	0.016	0.013	0	55.5	56.8	66.7	157	160	0	28	28
2025	4	7	3	43	9	0.764	-0.059	2.943	0.016	0.016	0	55.9	56.8	66.7	157	160	0	27	28
2025	4	7	3	53	9	0.771	-0.043	2.94	0.016	0.016	0	55.9	57.2	65.8	157	161	0	27	28
2025	4	7	4	3	9	0.764	-0.026	2.943	0.016	0.013	0	55.9	56.8	66.7	157	160	0	27	28
2025	4	7	4	13	9	0.751	-0.059	2.943	0.016	0.013	0	55.9	57.2	65.8	157	161	0	27	28
2025	4	7	4	23	9	0.794	-0.062	2.943	0.016	0.013	0	55.5	56.8	66.7	157	160	0	28	28
2025	4	7	4	33	9	0.741	-0.043	2.943	0.016	0.013	0	55.5	57.2	66.2	157	161	0	28	28
2025	4	7	4	43	9	0.774	-0.056	2.94	0.016	0.013	0	55.5	57.2	65.8	157	161	0	28	28
2025	4	7	4	53	9	0.781	-0.016	2.94	0.016	0.013	0	55.9	57.2	65.8	157	161	0	27	28
2025	4	7	5	3	9	0.774	-0.069	2.943	0.013	0.01	0	55.5	57.2	65.4	157	161	0	28	28
2025	4	7	5	13	9	0.764	-0.059	2.94	0.016	0.016	0	55.5	57.2	65.8	157	161	0	28	28
2025	4	7	5	23	9	0.794	-0.036	2.94	0.016	0.013	0	55.9	57.2	65.4	157	161	0	27	28
2025	4	7	5	33	9	0.774	-0.062	2.94	0.016	0.013	0	55.5	57.2	65.4	157	161	0	28	28
2025	4	7	5	43	9	0.771	-0.033	2.94	0.016	0.016	0	55.9	57.2	65.4	157	161	0	27	28
2025	4	7	5	53	9	0.794	-0.036	2.94	0.016	0.013	0	56.3	57.2	65.4	158	161	0	27	28
2025	4	7	6	3	9	0.761	-0.043	2.94	0.013	0.01	0	55.9	57.2	65.8	157	161	0	27	28
2025	4	7	6	13	9	0.787	-0.056	2.94	0.016	0.013	0	55.9	57.2	65.4	158	161	0	28	28
2025	4	7	6	23	9	0.771	-0.043	2.94	0.016	0.016	0	55.5	57.2	65.4	157	161	0	28	28
2025	4	7	6	33	9	0.755	-0.056	2.94	0.016	0.016	0	55.5	57.6	65.4	157	161	0	28	27
2025	4	7	6	43	9	0.807	-0.043	2.94	0.016	0.013	0	55.9	56.8	65.8	157	160	0	27	28
2025	4	7	6	53	9	0.751	-0.052	2.943	0.016	0.016	0	55.9	57.2	65.4	157	160	0	27	27
2025	4	7	7	3	9	0.784	-0.026	2.943	0.016	0.016	0	55.9	57.2	65.4	157	161	0	27	28
2025	4	7	7	13	9	0.784	-0.056	2.943	0.016	0.016	0	55.5	57.2	65.8	157	161	0	28	28
2025	4	7	7	23	9	0.804	-0.046	2.943	0.016	0.013	0	55.9	57.2	65.8	157	161	0	27	28
2025	4	7	7	33	9	0.732	-0.059	2.943	0.016	0.013	0	55.5	57.2	65.8	157	161	0	28	28
2025	4	7	7	43	9	0.784	-0.03	2.943	0.016	0.013	0	55.9	56.8	65.4	157	160	0	27	28
2025	4	7	7	53	9	0.774	-0.052	2.943	0.016	0.013	0	55.9	56.8	62.4	157	160	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	7	8	3	9	0.791	-0.046	2.94	0.016	0.016	0	55.5	56.8	55	157	160	0	28	28
2025	4	7	8	13	9	0.797	-0.072	2.943	0.016	0.013	0	55.5	56.8	66.2	157	160	0	28	28
2025	4	7	8	23	9	0.755	-0.049	2.943	0.016	0.013	0	55.9	56.8	56.8	157	160	0	27	28
2025	4	7	8	33	9	0.768	-0.03	2.943	0.02	0.016	0	55.5	57.2	52.5	157	161	0	28	28
2025	4	7	8	43	9	0.751	-0.03	2.943	0.016	0.016	0	55.9	57.2	61.1	157	161	0	27	28
2025	4	7	8	53	9	0.807	-0.039	2.943	0.016	0.013	0	55	56.3	59.8	156	160	0	28	29
2025	4	7	9	3	9	0.761	-0.033	2.943	0.016	0.016	0	55.5	56.8	65.4	157	160	0	28	28
2025	4	7	9	13	9	0.781	-0.079	2.943	0.016	0.013	0	55.5	56.3	51.2	156	160	0	27	29
2025	4	7	9	23	9	0.801	-0.069	2.943	0.016	0.013	0	56.3	56.8	49	158	160	0	27	28
2025	4	7	9	33	9	0.784	-0.039	2.943	0.016	0.013	0	55.9	56.3	45.2	157	159	0	27	28
2025	4	7	9	43	9	0.771	-0.059	2.943	0.016	0.016	0	55.5	56.8	42.6	157	160	0	28	28
2025	4	7	9	53	9	0.741	-0.046	2.943	0.016	0.016	0	56.3	57.2	58.9	158	161	0	27	28
2025	4	7	10	3	9	0.801	-0.062	2.943	0.02	0.016	0	55.9	56.8	44.7	157	160	0	27	28
2025	4	7	10	13	9	0.771	-0.075	2.943	0.016	0.016	0	56.3	56.8	48.6	158	160	0	27	28
2025	4	7	10	23	9	0.801	-0.043	2.946	0.016	0.013	0	55.5	56.3	45.6	157	159	0	28	28
2025	4	7	10	33	9	0.794	-0.039	2.946	0.013	0.01	0	55.5	56.8	43.4	157	160	0	28	28
2025	4	7	10	43	9	0.784	-0.039	2.946	0.013	0.01	0	55.9	56.3	46	157	159	0	27	28
2025	4	7	10	53	9	0.778	-0.039	2.946	0.016	0.013	0	55.9	56.8	47.7	157	160	0	27	28
2025	4	7	11	3	9	0.764	-0.026	2.946	0.016	0.016	0	55.5	57.2	46	157	161	0	28	28
2025	4	7	11	13	9	0.741	-0.039	2.946	0.016	0.016	0	55.9	56.8	43.9	157	160	0	27	28
2025	4	7	11	23	9	0.748	-0.082	2.949	0.016	0.013	0	55.9	56.8	44.3	157	160	0	27	28
2025	4	7	11	33	9	0.82	-0.056	2.946	0.013	0.01	0	55.9	56.8	40.9	157	160	0	27	28
2025	4	7	11	43	9	0.784	-0.056	2.946	0.016	0.016	0	55.9	56.3	41.7	157	159	0	27	28
2025	4	7	11	53	9	0.797	-0.043	2.949	0.013	0.01	0	55.9	56.8	43	157	160	0	27	28
2025	4	7	12	3	9	0.781	-0.026	2.949	0.016	0.013	0	55	57.2	44.7	156	160	0	28	27
2025	4	7	12	13	9	0.804	-0.056	2.946	0.016	0.013	0	55.9	57.2	46	157	160	0	27	27
2025	4	7	12	23	9	0.82	-0.062	2.949	0.016	0.016	0	55.9	56.8	46.9	157	160	0	27	28
2025	4	7	12	33	9	0.732	-0.056	2.949	0.016	0.013	0	55.9	56.8	42.1	157	160	0	27	28
2025	4	7	12	43	9	0.814	-0.052	2.949	0.013	0.01	0	55.9	56.8	46	157	160	0	27	28
2025	4	7	12	53	9	0.791	-0.043	2.949	0.016	0.013	0	55.5	56.3	40.4	156	160	0	27	29
2025	4	7	13	3	9	0.755	-0.039	2.953	0.02	0.016	0	55.9	56.3	40.4	157	160	0	27	29
2025	4	7	13	13	9	0.778	-0.052	2.949	0.016	0.016	0	55.5	56.8	38.7	156	160	0	27	28
2025	4	7	13	23	9	0.781	-0.059	2.953	0.016	0.013	0	55	56.8	41.3	156	160	0	28	28
2025	4	7	13	33	9	0.784	-0.069	2.949	0.016	0.016	0	55.9	56.3	43	156	159	0	26	28
2025	4	7	13	43	9	0.823	-0.066	2.949	0.016	0.013	0	55.5	56.8	39.1	156	159	0	27	27
2025	4	7	13	53	9	0.778	-0.066	2.949	0.016	0.016	0	55.9	56.8	38.7	157	160	0	27	28
2025	4	7	14	3	9	0.82	-0.016	2.953	0.013	0.01	0	55.9	57.2	41.3	157	160	0	27	27
2025	4	7	14	13	9	0.83	-0.043	2.953	0.016	0.013	0	55.5	57.2	41.3	156	160	0	27	27
2025	4	7	14	23	9	0.807	-0.052	2.953	0.016	0.016	0	55.5	57.2	42.6	156	160	0	27	27
2025	4	7	14	33	9	0.774	-0.059	2.949	0.016	0.013	0	55.9	57.2	40.4	157	160	0	27	27
2025	4	7	14	43	9	0.801	-0.039	2.956	0.02	0.016	0	55.9	57.6	46.9	157	161	0	27	27
2025	4	7	14	53	9	0.761	-0.056	2.956	0.016	0.016	0	56.3	57.2	44.7	158	161	0	27	28
2025	4	7	15	3	9	0.771	-0.052	2.953	0.023	0.02	0	55.9	57.2	43.9	157	161	0	27	28
2025	4	7	15	13	9	0.804	-0.02	2.956	0.016	0.013	0	56.3	57.2	43.4	158	161	0	27	28
2025	4	7	15	23	9	0.761	-0.046	2.953	0.016	0.016	0	56.8	57.6	41.3	158	161	0	26	27
2025	4	7	15	33	9	0.758	-0.056	2.953	0.016	0.013	0	56.3	58	44.3	158	162	0	27	27
2025	4	7	15	43	9	0.784	-0.049	2.953	0.016	0.013	0	55.9	57.6	43	157	161	0	27	27
2025	4	7	15	53	9	0.778	-0.072	2.953	0.016	0.016	0	56.8	57.6	41.7	158	161	0	26	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	7	16	3	9	0.781	-0.033	2.956	0.016	0.013	0	56.8	58	46	159	162	0	27	27
2025	4	7	16	13	9	0.804	-0.02	2.956	0.016	0.013	0	56.8	58	47.7	158	162	0	26	27
2025	4	7	16	23	9	0.804	-0.059	2.956	0.016	0.013	0	56.3	58	42.1	158	162	0	27	27
2025	4	7	16	33	9	0.81	-0.016	2.959	0.013	0.01	0	56.3	58	67.1	158	162	0	27	27
2025	4	7	16	43	9	0.784	0	2.959	0.016	0.016	0	56.8	57.6	67.9	159	162	0	27	28
2025	4	7	16	53	9	0.797	-0.03	2.956	0.016	0.016	0	56.8	58	48.2	158	162	0	26	27
2025	4	7	17	3	9	0.797	-0.052	2.959	0.016	0.016	0	56.3	57.6	67.5	157	161	0	26	27
2025	4	7	17	13	9	0.771	-0.03	2.959	0.016	0.013	0	56.3	58	66.2	158	162	0	27	27
2025	4	7	17	23	9	0.768	-0.013	2.959	0.016	0.016	0	56.8	58.5	64.1	159	163	0	27	27
2025	4	7	17	33	9	0.797	-0.052	2.956	0.016	0.016	0	56.3	57.6	58.9	158	162	0	27	28
2025	4	7	17	43	9	0.781	-0.016	2.956	0.016	0.016	0	56.3	57.6	57.2	158	162	0	27	28
2025	4	7	17	53	9	0.768	-0.023	2.956	0.016	0.013	0	56.8	57.6	58	158	162	0	26	28
2025	4	7	18	3	9	0.797	-0.062	2.956	0.016	0.013	0	56.3	57.6	50.7	158	161	0	27	27
2025	4	7	18	13	9	0.781	-0.049	2.956	0.016	0.013	0	56.8	58	61.1	159	162	0	27	27
2025	4	7	18	23	9	0.761	-0.02	2.956	0.016	0.016	0	56.8	58	61.1	159	162	0	27	27
2025	4	7	18	33	9	0.833	-0.056	2.956	0.016	0.013	0	56.3	58	62.4	158	162	0	27	27
2025	4	7	18	43	9	0.794	-0.075	2.956	0.016	0.013	0	57.6	57.6	58.5	160	162	0	26	28
2025	4	7	18	53	9	0.801	-0.049	2.956	0.016	0.013	0	56.8	58	59.8	159	162	0	27	27
2025	4	7	19	3	9	0.745	-0.056	2.956	0.013	0.01	0	57.2	58.5	61.1	160	163	0	27	27
2025	4	7	19	13	9	0.778	-0.059	2.953	0.016	0.016	0	57.2	58.5	62.8	160	163	0	27	27
2025	4	7	19	23	9	0.787	-0.043	2.953	0.016	0.016	0	56.8	58.5	57.2	159	163	0	27	27
2025	4	7	19	33	9	0.755	-0.026	2.953	0.016	0.016	0	57.6	58.5	65.8	161	163	0	27	27
2025	4	7	19	43	9	0.755	-0.036	2.953	0.016	0.016	0	56.8	58	66.7	159	162	0	27	27
2025	4	7	19	53	9	0.748	-0.03	2.953	0.016	0.016	0	57.2	58.5	66.7	160	163	0	27	27
2025	4	7	20	3	9	0.781	-0.03	2.953	0.016	0.013	0	56.8	58	66.2	159	162	0	27	27
2025	4	7	20	13	9	0.768	-0.033	2.953	0.016	0.013	0	56.8	58	64.9	159	163	0	27	28
2025	4	7	20	23	9	0.761	-0.046	2.953	0.016	0.013	0	57.2	58.5	66.2	160	163	0	27	27
2025	4	7	20	33	9	0.758	-0.033	2.953	0.016	0.013	0	56.8	58	65.8	159	162	0	27	27
2025	4	7	20	43	9	0.748	-0.02	2.953	0.016	0.013	0	57.6	58	66.7	160	163	0	26	28
2025	4	7	20	53	9	0.787	-0.03	2.953	0.016	0.013	0	56.8	58	66.2	159	162	0	27	27
2025	4	7	21	3	9	0.755	-0.03	2.953	0.016	0.013	0	56.8	58	65.8	159	162	0	27	27
2025	4	7	21	13	9	0.764	-0.069	2.949	0.016	0.013	0	57.2	57.6	65.8	159	162	0	26	28
2025	4	7	21	23	9	0.787	-0.046	2.949	0.016	0.016	0	56.8	58	65.4	159	162	0	27	27
2025	4	7	21	33	9	0.778	-0.046	2.949	0.016	0.013	0	56.8	58	66.2	159	162	0	27	27
2025	4	7	21	43	9	0.804	-0.066	2.949	0.016	0.013	0	56.3	58	66.7	158	162	0	27	27
2025	4	7	21	53	9	0.761	-0.033	2.949	0.016	0.013	0	56.8	58	62.4	159	162	0	27	27
2025	4	7	22	3	9	0.801	-0.059	2.949	0.016	0.013	0	56.3	57.6	66.2	158	161	0	27	27
2025	4	7	22	13	9	0.791	-0.075	2.949	0.016	0.013	0	56.3	57.6	65.8	158	161	0	27	27
2025	4	7	22	23	9	0.768	-0.069	2.946	0.013	0.01	0	56.3	57.6	65.8	158	161	0	27	27
2025	4	7	22	33	9	0.768	-0.046	2.946	0.013	0.01	0	56.8	57.2	66.2	158	161	0	26	28
2025	4	7	22	43	9	0.797	-0.072	2.946	0.013	0.01	0	56.3	57.2	65.8	158	161	0	27	28
2025	4	7	22	53	9	0.761	-0.046	2.946	0.016	0.016	0	56.8	58	66.2	159	162	0	27	27
2025	4	7	23	3	9	0.791	-0.052	2.946	0.016	0.013	0	56.3	57.2	66.2	158	161	0	27	28
2025	4	7	23	13	9	0.784	-0.046	2.946	0.016	0.016	0	56.8	58	66.2	159	162	0	27	27
2025	4	7	23	23	9	0.768	-0.059	2.946	0.016	0.016	0	56.3	57.6	66.2	158	161	0	27	27
2025	4	7	23	33	9	0.755	-0.046	2.946	0.02	0.016	0	56.3	57.2	67.1	158	161	0	27	28
2025	4	7	23	43	9	0.814	-0.056	2.946	0.016	0.013	0	56.3	57.6	66.7	158	161	0	27	27
2025	4	7	23	53	9	0.774	-0.052	2.946	0.013	0.01	0	56.3	57.6	66.2	158	162	0	27	28

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	8	0	3	9	0.794	-0.043	2.946	0.016	0.016	0	56.3	57.2	66.2	158	161	0	27	28
2025	4	8	0	13	9	0.771	-0.059	2.943	0.016	0.013	0	56.8	57.2	66.7	158	161	0	26	28
2025	4	8	0	23	9	0.758	-0.03	2.943	0.016	0.013	0	56.3	57.6	67.1	158	162	0	27	28
2025	4	8	0	33	9	0.807	-0.03	2.943	0.016	0.016	0	56.3	57.2	67.5	158	161	0	27	28
2025	4	8	0	43	9	0.774	-0.043	2.943	0.016	0.016	0	56.3	57.6	67.5	158	161	0	27	27
2025	4	8	0	53	9	0.771	-0.046	2.943	0.016	0.013	0	56.3	57.2	67.5	158	161	0	27	28
2025	4	8	1	3	9	0.745	-0.03	2.943	0.016	0.016	0	56.3	58	67.1	158	162	0	27	27
2025	4	8	1	13	9	0.755	-0.062	2.943	0.02	0.016	0	56.3	57.6	67.5	158	161	0	27	27
2025	4	8	1	23	9	0.781	-0.046	2.943	0.016	0.016	0	55.9	57.6	67.9	158	161	0	28	27
2025	4	8	1	33	9	0.774	-0.046	2.943	0.016	0.016	0	56.3	57.6	67.1	158	161	0	27	27
2025	4	8	1	43	9	0.787	-0.043	2.943	0.016	0.013	0	56.3	57.6	67.5	158	161	0	27	27
2025	4	8	1	53	9	0.774	0	2.943	0.013	0.01	0	55.9	57.2	67.9	157	161	0	27	28
2025	4	8	2	3	9	0.774	-0.033	2.943	0.016	0.016	0	56.3	57.6	67.5	158	161	0	27	27
2025	4	8	2	13	9	0.827	0	2.943	0.016	0.013	0	55.9	57.2	67.5	158	161	0	28	28
2025	4	8	2	23	9	0.764	-0.056	2.943	0.016	0.013	0	56.3	57.2	67.9	158	161	0	27	28
2025	4	8	2	33	9	0.794	-0.056	2.94	0.016	0.016	0	56.3	57.6	67.5	158	162	0	27	28
2025	4	8	2	43	9	0.761	-0.046	2.94	0.013	0.01	0	56.3	57.6	67.9	158	162	0	27	28
2025	4	8	2	53	9	0.741	-0.007	2.94	0.016	0.016	0	56.3	57.2	67.9	158	161	0	27	28
2025	4	8	3	3	9	0.781	-0.056	2.94	0.016	0.013	0	56.3	57.6	67.5	158	161	0	27	27
2025	4	8	3	13	9	0.741	-0.023	2.94	0.016	0.013	0	55.9	58	67.9	158	162	0	28	27
2025	4	8	3	23	9	0.764	-0.026	2.94	0.013	0.01	0	56.3	57.2	67.5	158	161	0	27	28
2025	4	8	3	33	9	0.771	-0.046	2.94	0.016	0.016	0	56.8	57.2	67.9	159	161	0	27	28
2025	4	8	3	43	9	0.771	-0.072	2.94	0.016	0.013	0	56.3	57.2	68.4	158	161	0	27	28
2025	4	8	3	53	9	0.745	-0.026	2.94	0.02	0.016	0	56.8	57.6	67.9	159	162	0	27	28
2025	4	8	4	3	9	0.761	-0.043	2.94	0.016	0.013	0	56.8	57.2	67.5	159	161	0	27	28
2025	4	8	4	13	9	0.768	-0.075	2.94	0.016	0.013	0	56.3	57.2	68.4	158	161	0	27	28
2025	4	8	4	23	9	0.768	-0.039	2.94	0.016	0.013	0	56.3	57.2	67.9	158	161	0	27	28
2025	4	8	4	33	9	0.804	-0.02	2.94	0.016	0.013	0	56.8	57.2	67.9	159	161	0	27	28
2025	4	8	4	43	9	0.751	-0.039	2.94	0.016	0.016	0	56.8	57.6	67.9	159	161	0	27	27
2025	4	8	4	53	9	0.732	-0.059	2.94	0.016	0.016	0	56.8	57.2	67.5	159	161	0	27	28
2025	4	8	5	3	9	0.774	-0.046	2.94	0.013	0.01	0	56.8	57.6	67.9	159	162	0	27	28
2025	4	8	5	13	9	0.758	-0.043	2.94	0.016	0.016	0	56.8	57.6	67.5	159	162	0	27	28
2025	4	8	5	23	9	0.778	-0.066	2.94	0.016	0.013	0	56.8	57.6	67.5	159	162	0	27	28
2025	4	8	5	33	9	0.758	-0.052	2.94	0.016	0.013	0	56.8	57.6	62.4	160	162	0	28	28
2025	4	8	5	43	9	0.758	-0.036	2.94	0.016	0.013	0	57.2	58.5	67.5	160	163	0	27	27
2025	4	8	5	53	9	0.771	-0.013	2.94	0.016	0.016	0	56.8	58	68.4	160	162	0	28	27
2025	4	8	6	3	9	0.784	-0.062	2.936	0.016	0.013	0	56.3	57.6	67.9	159	162	0	28	28
2025	4	8	6	13	9	0.751	-0.066	2.94	0.016	0.016	0	56.3	57.6	67.1	159	162	0	28	28
2025	4	8	6	23	9	0.778	-0.056	2.936	0.016	0.013	0	56.8	57.6	68.4	159	162	0	27	28
2025	4	8	6	33	9	0.758	-0.046	2.936	0.016	0.016	0	56.8	58	67.9	159	162	0	27	27
2025	4	8	6	43	9	0.764	-0.046	2.936	0.016	0.013	0	55.9	57.2	67.5	158	162	0	28	29
2025	4	8	6	53	9	0.791	-0.062	2.936	0.016	0.013	0	56.3	57.6	67.5	159	162	0	28	28
2025	4	8	7	3	9	0.761	-0.046	2.936	0.013	0.01	0	56.8	57.2	67.9	159	162	0	27	29
2025	4	8	7	13	9	0.761	-0.056	2.936	0.013	0.01	0	56.3	58	67.9	159	162	0	28	27
2025	4	8	7	23	9	0.725	-0.046	2.936	0.016	0.013	0	56.3	58	68.8	159	163	0	28	28
2025	4	8	7	33	9	0.771	-0.056	2.936	0.016	0.013	0	56.8	57.6	67.9	159	162	0	27	28
2025	4	8	7	43	9	0.761	-0.013	2.936	0.013	0.01	0	56.8	57.6	67.9	159	162	0	27	28
2025	4	8	7	53	9	0.784	-0.049	2.936	0.016	0.013	0	56.8	57.6	68.8	159	162	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	8	8	3	9	0.791	-0.036	2.936	0.016	0.013	0	56.3	57.2	69.2	159	162	0	28	29
2025	4	8	8	13	9	0.778	-0.046	2.936	0.016	0.016	0	56.3	57.6	68.4	159	162	0	28	28
2025	4	8	8	23	9	0.751	-0.066	2.936	0.016	0.013	0	56.8	58	68.4	159	162	0	27	27
2025	4	8	8	33	9	0.768	-0.03	2.936	0.016	0.013	0	56.3	57.6	64.9	158	162	0	27	28
2025	4	8	8	43	9	0.745	-0.052	2.94	0.016	0.016	0	56.3	57.6	66.7	159	162	0	28	28
2025	4	8	8	53	9	0.787	-0.036	2.94	0.016	0.013	0	56.8	57.6	68.4	159	162	0	27	28
2025	4	8	9	3	9	0.758	-0.023	2.936	0.016	0.016	0	55.9	57.2	54.2	158	161	0	28	28
2025	4	8	9	13	9	0.784	-0.049	2.94	0.016	0.013	0	56.3	57.6	57.6	158	161	0	27	27
2025	4	8	9	23	9	0.758	-0.033	2.94	0.016	0.013	0	55.5	57.2	67.1	157	161	0	28	28
2025	4	8	9	33	9	0.761	-0.036	2.94	0.016	0.013	0	56.3	57.2	68.4	158	161	0	27	28
2025	4	8	9	43	9	0.794	-0.043	2.94	0.016	0.013	0	55.9	57.2	50.3	157	161	0	27	28
2025	4	8	9	53	9	0.761	-0.036	2.94	0.016	0.016	0	55.9	57.6	49.5	157	161	0	27	27
2025	4	8	10	3	9	0.778	-0.02	2.94	0.016	0.013	0	55.9	57.2	53.3	157	161	0	27	28
2025	4	8	10	13	9	0.764	-0.03	2.94	0.016	0.016	0	55.9	57.6	48.2	158	162	0	28	28
2025	4	8	10	23	9	0.774	-0.039	2.936	0.013	0.01	0	56.3	57.2	43.4	158	161	0	27	28
2025	4	8	10	33	9	0.755	-0.033	2.94	0.02	0.016	0	55.9	57.2	47.3	158	161	0	28	28
2025	4	8	10	43	9	0.784	-0.046	2.94	0.016	0.013	0	55.9	57.2	43.4	157	161	0	27	28
2025	4	8	10	53	9	0.774	-0.023	2.94	0.016	0.016	0	55.5	57.2	43	157	161	0	28	28
2025	4	8	11	3	9	0.794	-0.059	2.94	0.016	0.013	0	55.5	57.6	45.2	157	161	0	28	27
2025	4	8	11	13	9	0.738	-0.092	2.94	0.016	0.013	0	56.3	57.2	46.9	158	161	0	27	28
2025	4	8	11	23	9	0.748	-0.056	2.936	0.016	0.013	0	56.3	57.6	42.1	158	161	0	27	27
2025	4	8	11	33	9	0.781	-0.056	2.936	0.016	0.013	0	55.9	57.2	39.1	158	161	0	28	28
2025	4	8	11	43	9	0.761	-0.033	2.936	0.016	0.013	0	55.9	57.6	43.4	157	161	0	27	27
2025	4	8	11	53	9	0.791	-0.02	2.94	0.016	0.013	0	56.8	57.6	48.6	158	162	0	26	28
2025	4	8	12	3	9	0.81	-0.075	2.936	0.016	0.016	0	56.3	57.6	42.6	158	162	0	27	28
2025	4	8	12	13	9	0.797	-0.069	2.936	0.016	0.016	0	56.3	58	41.7	158	162	0	27	27
2025	4	8	12	23	9	0.784	-0.049	2.936	0.02	0.016	0	56.3	57.6	45.2	158	162	0	27	28
2025	4	8	12	33	9	0.758	-0.062	2.936	0.02	0.016	0	56.8	58.5	56.3	159	163	0	27	27
2025	4	8	12	43	9	0.748	-0.026	2.936	0.016	0.016	0	56.8	58.5	46	159	163	0	27	27
2025	4	8	12	53	9	0.751	-0.033	2.933	0.016	0.016	0	57.6	58.5	57.2	160	163	0	26	27
2025	4	8	13	3	9	0.778	-0.033	2.936	0.016	0.016	0	57.2	58	64.9	160	163	0	27	28
2025	4	8	13	13	9	0.774	-0.023	2.933	0.016	0.016	0	56.8	58.5	48.6	159	163	0	27	27
2025	4	8	13	23	9	0.781	-0.059	2.936	0.016	0.016	0	56.8	58	61.1	159	163	0	27	28
2025	4	8	13	33	9	0.761	-0.036	2.936	0.013	0.01	0	56.8	58.5	44.7	159	163	0	27	27
2025	4	8	13	43	9	0.797	-0.039	2.936	0.016	0.016	0	57.2	58.5	50.3	160	163	0	27	27
2025	4	8	13	53	9	0.791	-0.059	2.936	0.016	0.013	0	57.2	58.5	63.2	160	163	0	27	27
2025	4	8	14	3	9	0.751	-0.01	2.936	0.02	0.016	0	57.6	58.5	51.6	160	163	0	26	27
2025	4	8	14	13	9	0.801	-0.075	2.94	0.016	0.016	0	56.8	58	44.7	159	163	0	27	28
2025	4	8	14	23	9	0.807	-0.033	2.936	0.02	0.016	0	57.2	58.5	58.9	160	163	0	27	27
2025	4	8	14	33	9	0.774	-0.046	2.94	0.016	0.013	0	57.2	58.5	42.1	160	163	0	27	27
2025	4	8	14	43	9	0.774	-0.082	2.94	0.016	0.016	0	57.2	58.5	41.7	159	163	0	26	27
2025	4	8	14	53	9	0.764	-0.062	2.936	0.016	0.016	0	56.8	58	46.4	159	163	0	27	28
2025	4	8	15	3	9	0.787	-0.049	2.94	0.016	0.016	0	57.2	58.9	53.3	160	164	0	27	27
2025	4	8	15	13	9	0.787	-0.039	2.94	0.016	0.016	0	57.6	58.5	43.4	160	163	0	26	27
2025	4	8	15	23	9	0.761	-0.059	2.94	0.016	0.013	0	57.6	58.5	47.7	160	163	0	26	27
2025	4	8	15	33	9	0.781	-0.023	2.943	0.016	0.013	0	57.2	58.5	40.9	160	163	0	27	27
2025	4	8	15	43	9	0.784	-0.043	2.943	0.02	0.016	0	57.2	58.9	40.4	160	163	0	27	26
2025	4	8	15	53	9	0.781	-0.039	2.946	0.02	0.016	0	57.2	58.9	42.1	160	164	0	27	27

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	8	16	3	9	0.761	-0.033	2.943	0.016	0.013	0	57.6	58.5	39.6	160	163	0	26	27
2025	4	8	16	13	9	0.764	-0.036	2.943	0.02	0.016	0	57.6	58.9	43.4	160	163	0	26	26
2025	4	8	16	23	9	0.778	-0.033	2.943	0.02	0.016	0	57.2	58.5	39.1	159	163	0	26	27
2025	4	8	16	33	9	0.791	-0.046	2.943	0.016	0.013	0	57.6	58.5	41.3	160	163	0	26	27
2025	4	8	16	43	9	0.784	-0.036	2.943	0.016	0.013	0	58	58.9	39.1	161	164	0	26	27
2025	4	8	16	53	9	0.791	-0.046	2.94	0.016	0.016	0	57.2	58.5	43	160	163	0	27	27
2025	4	8	17	3	9	0.81	-0.069	2.943	0.013	0.01	0	57.2	58	42.1	159	162	0	26	27
2025	4	8	17	13	9	0.741	-0.026	2.94	0.016	0.013	0	57.6	58.5	44.7	160	163	0	26	27
2025	4	8	17	23	9	0.804	-0.049	2.94	0.016	0.016	0	57.2	58	43.4	159	162	0	26	27
2025	4	8	17	33	9	0.755	-0.046	2.94	0.02	0.016	0	57.2	58.5	47.7	159	163	0	26	27
2025	4	8	17	43	9	0.774	-0.036	2.94	0.016	0.016	0	57.2	58.5	48.2	159	163	0	26	27
2025	4	8	17	53	9	0.787	-0.023	2.94	0.016	0.016	0	57.2	58.5	61.9	159	163	0	26	27
2025	4	8	18	3	9	0.778	-0.016	2.94	0.016	0.016	0	57.2	58.5	65.8	159	163	0	26	27
2025	4	8	18	13	9	0.791	-0.02	2.94	0.016	0.013	0	57.6	58.9	65.8	160	164	0	26	27
2025	4	8	18	23	9	0.797	-0.049	2.94	0.016	0.016	0	57.2	58.9	66.7	160	163	0	27	26
2025	4	8	18	33	9	0.771	-0.062	2.94	0.016	0.013	0	57.2	58.5	66.7	160	163	0	27	27
2025	4	8	18	43	9	0.807	-0.016	2.94	0.016	0.013	0	57.2	59.3	65.8	160	164	0	27	26
2025	4	8	18	53	9	0.755	0	2.94	0.016	0.013	0	57.6	58.9	65.4	160	164	0	26	27
2025	4	8	19	3	9	0.761	-0.043	2.94	0.016	0.016	0	57.6	58.9	65.8	161	164	0	27	27
2025	4	8	19	13	9	0.774	-0.062	2.94	0.02	0.016	0	57.6	58.5	65.8	160	163	0	26	27
2025	4	8	19	23	9	0.781	-0.056	2.94	0.016	0.013	0	57.6	58.9	65.4	161	164	0	27	27
2025	4	8	19	33	9	0.787	-0.016	2.94	0.02	0.016	0	57.6	58.5	65.8	160	163	0	26	27
2025	4	8	19	43	9	0.768	-0.016	2.936	0.016	0.013	0	57.6	58.5	65.8	160	163	0	26	27
2025	4	8	19	53	9	0.735	-0.016	2.936	0.016	0.016	0	57.6	58.9	65.8	161	164	0	27	27
2025	4	8	20	3	9	0.797	-0.049	2.936	0.016	0.013	0	57.2	58.9	66.2	160	164	0	27	27
2025	4	8	20	13	9	0.81	-0.003	2.936	0.016	0.013	0	57.2	58.5	65.8	160	163	0	27	27
2025	4	8	20	23	9	0.771	-0.01	2.936	0.016	0.016	0	57.2	58.9	65.4	160	164	0	27	27
2025	4	8	20	33	9	0.784	-0.043	2.936	0.016	0.016	0	57.6	58.5	64.1	160	163	0	26	27
2025	4	8	20	43	9	0.784	-0.059	2.936	0.016	0.013	0	57.2	58.9	65.8	160	164	0	27	27
2025	4	8	20	53	9	0.758	-0.033	2.936	0.02	0.016	0	57.6	58.5	65.8	160	164	0	26	28
2025	4	8	21	3	9	0.771	-0.062	2.936	0.016	0.016	0	57.6	58.9	65.8	160	164	0	26	27
2025	4	8	21	13	9	0.791	-0.072	2.933	0.02	0.016	0	57.2	58.9	65.8	160	164	0	27	27
2025	4	8	21	23	9	0.781	0	2.936	0.016	0.013	0	57.2	58.9	65.4	160	164	0	27	27
2025	4	8	21	33	9	0.768	-0.036	2.933	0.016	0.013	0	57.2	58.5	65.8	160	163	0	27	27
2025	4	8	21	43	9	0.764	0.007	2.933	0.016	0.013	0	57.2	58.9	65.8	160	164	0	27	27
2025	4	8	21	53	9	0.797	-0.046	2.933	0.016	0.013	0	57.6	58.9	66.2	160	164	0	26	27
2025	4	8	22	3	9	0.778	-0.075	2.933	0.013	0.01	0	57.2	59.3	65.8	160	164	0	27	26
2025	4	8	22	13	9	0.748	-0.062	2.933	0.016	0.013	0	57.6	58.9	65.4	160	164	0	26	27
2025	4	8	22	23	9	0.722	-0.016	2.933	0.016	0.013	0	57.2	58.9	65.4	160	164	0	27	27
2025	4	8	22	33	9	0.764	-0.056	2.93	0.016	0.016	0	57.2	58.9	65.8	160	164	0	27	27
2025	4	8	22	43	9	0.732	-0.056	2.93	0.016	0.013	0	56.3	58.5	65.8	159	163	0	28	27
2025	4	8	22	53	9	0.771	-0.043	2.93	0.016	0.016	0	57.2	58.5	64.9	160	164	0	27	28
2025	4	8	23	3	9	0.804	-0.046	2.93	0.016	0.016	0	57.2	58.5	65.4	160	163	0	27	27
2025	4	8	23	13	9	0.748	-0.02	2.93	0.016	0.013	0	57.2	58.9	64.9	160	164	0	27	27
2025	4	8	23	23	9	0.791	-0.03	2.93	0.016	0.016	0	57.6	58.9	65.4	160	164	0	26	27
2025	4	8	23	33	9	0.787	-0.046	2.93	0.016	0.016	0	57.2	58.9	65.4	160	164	0	27	27
2025	4	8	23	43	9	0.761	-0.105	2.93	0.016	0.013	0	57.2	58.9	65.8	160	164	0	27	27
2025	4	8	23	53	9	0.748	-0.036	2.93	0.016	0.013	0	57.2	58.9	65.4	160	164	0	27	27

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	9	0	3	9	0.778	-0.033	2.93	0.016	0.016	0	57.6	58.5	65.8	160	164	0	26	28
2025	4	9	0	13	9	0.758	-0.02	2.927	0.016	0.016	0	57.2	58.9	65.4	160	164	0	27	27
2025	4	9	0	23	9	0.787	-0.049	2.927	0.016	0.013	0	57.2	58.9	65.8	160	164	0	27	27
2025	4	9	0	33	9	0.778	-0.03	2.927	0.016	0.016	0	57.2	58.5	65.4	160	164	0	27	28
2025	4	9	0	43	9	0.771	-0.056	2.927	0.016	0.013	0	57.6	58.5	64.5	161	164	0	27	28
2025	4	9	0	53	9	0.751	-0.046	2.927	0.016	0.016	0	57.6	58.5	64.9	161	164	0	27	28
2025	4	9	1	3	9	0.791	-0.046	2.927	0.016	0.013	0	57.6	58.9	65.4	161	164	0	27	27
2025	4	9	1	13	9	0.751	-0.046	2.927	0.016	0.016	0	57.6	58.5	64.9	161	164	0	27	28
2025	4	9	1	23	9	0.751	-0.026	2.927	0.016	0.013	0	57.6	58.9	59.3	161	164	0	27	27
2025	4	9	1	33	9	0.784	-0.046	2.927	0.02	0.016	0	57.2	58.9	62.8	160	164	0	27	27
2025	4	9	1	43	9	0.764	-0.069	2.927	0.016	0.013	0	57.6	58.9	63.2	161	165	0	27	28
2025	4	9	1	53	9	0.745	-0.062	2.927	0.016	0.013	0	57.6	58.5	64.5	161	164	0	27	28
2025	4	9	2	3	9	0.725	-0.052	2.927	0.016	0.016	0	57.6	58.9	64.1	161	164	0	27	27
2025	4	9	2	13	9	0.755	-0.039	2.927	0.016	0.013	0	57.2	58.5	64.1	160	164	0	27	28
2025	4	9	2	23	9	0.722	-0.013	2.923	0.016	0.016	0	57.6	58.9	63.6	161	165	0	27	28
2025	4	9	2	33	9	0.764	-0.066	2.927	0.016	0.013	0	57.2	58.5	64.5	160	164	0	27	28
2025	4	9	2	43	9	0.728	-0.016	2.927	0.016	0.013	0	57.2	58	64.1	160	163	0	27	28
2025	4	9	2	53	9	0.761	-0.085	2.927	0.016	0.013	0	57.2	58.9	64.1	161	164	0	28	27
2025	4	9	3	3	9	0.781	-0.023	2.927	0.016	0.016	0	57.6	58.9	63.2	161	164	0	27	27
2025	4	9	3	13	9	0.761	-0.056	2.927	0.016	0.013	0	57.2	58.5	63.2	160	164	0	27	28
2025	4	9	3	23	9	0.761	-0.039	2.927	0.016	0.013	0	57.2	58	57.6	160	163	0	27	28
2025	4	9	3	33	9	0.758	-0.075	2.93	0.016	0.013	0	57.2	58.9	63.2	161	164	0	28	27
2025	4	9	3	43	9	0.751	-0.036	2.933	0.016	0.016	0	57.6	58.9	63.2	161	164	0	27	27
2025	4	9	3	53	9	0.748	-0.03	2.933	0.016	0.013	0	57.6	58.5	62.8	161	164	0	27	28
2025	4	9	4	3	9	0.791	-0.036	2.936	0.013	0.01	0	57.2	58	63.6	160	163	0	27	28
2025	4	9	4	13	9	0.735	-0.043	2.936	0.016	0.013	0	56.8	58	63.6	159	163	0	27	28
2025	4	9	4	23	9	0.755	-0.039	2.936	0.016	0.013	0	56.8	58	63.6	160	163	0	28	28
2025	4	9	4	33	9	0.774	-0.03	2.94	0.02	0.016	0	56.8	58	64.5	159	163	0	27	28
2025	4	9	4	43	9	0.781	-0.049	2.94	0.016	0.016	0	57.2	58.5	64.5	160	164	0	27	28
2025	4	9	4	53	9	0.755	-0.016	2.94	0.016	0.016	0	57.2	58.5	64.9	160	164	0	27	28
2025	4	9	5	3	9	0.774	-0.072	2.94	0.016	0.013	0	57.2	58	65.4	160	163	0	27	28
2025	4	9	5	13	9	0.764	-0.082	2.94	0.02	0.016	0	57.2	58.5	65.4	160	164	0	27	28
2025	4	9	5	23	9	0.787	-0.016	2.943	0.016	0.016	0	56.8	58.9	65.8	160	164	0	28	27
2025	4	9	5	33	9	0.801	-0.043	2.943	0.016	0.013	0	56.8	58.5	67.1	159	163	0	27	27
2025	4	9	5	43	9	0.781	-0.03	2.943	0.016	0.016	0	57.6	58.9	67.1	160	164	0	26	27
2025	4	9	5	53	9	0.814	-0.039	2.943	0.02	0.016	0	57.2	58.5	66.7	160	164	0	27	28
2025	4	9	6	3	9	0.741	-0.046	2.943	0.016	0.016	0	57.2	58.9	66.7	161	164	0	28	27
2025	4	9	6	13	9	0.741	-0.056	2.946	0.016	0.013	0	57.2	58.5	66.7	160	164	0	27	28
2025	4	9	6	23	9	0.781	-0.079	2.946	0.016	0.016	0	57.2	58.5	67.1	160	164	0	27	28
2025	4	9	6	33	9	0.738	-0.03	2.946	0.016	0.013	0	57.2	58.5	66.7	160	164	0	27	28
2025	4	9	6	43	9	0.735	-0.036	2.946	0.016	0.013	0	57.6	58.9	66.7	161	165	0	27	28
2025	4	9	6	53	9	0.768	-0.039	2.946	0.016	0.013	0	57.2	58.5	66.2	161	164	0	28	28
2025	4	9	7	3	9	0.768	-0.079	2.946	0.016	0.016	0	57.6	58.9	66.7	161	165	0	27	28
2025	4	9	7	13	9	0.784	-0.016	2.949	0.016	0.013	0	57.6	59.3	66.2	161	165	0	27	27
2025	4	9	7	23	9	0.784	-0.039	2.949	0.016	0.013	0	57.6	58.9	66.2	161	165	0	27	28
2025	4	9	7	33	9	0.784	-0.03	2.949	0.016	0.016	0	57.6	58.9	65.8	161	165	0	27	28
2025	4	9	7	43	9	0.774	-0.033	2.953	0.01	0.007	0	57.2	58.9	65.8	160	165	0	27	28
2025	4	9	7	53	9	0.797	-0.043	2.953	0.016	0.013	0	57.2	58.9	66.2	160	164	0	27	27

Mazourka (0354)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	
2025	4	9	8	3	9	0.784	-0.046	2.953	0.016	0.016	0	57.2	58.9	65.4	160	165	0	27	28	
2025	4	9	8	13	9	0.801	-0.066	2.956	0.016	0.016	0	57.2	58.9	64.9	160	164	0	27	27	
2025	4	9	8	23	9	0.771	-0.043	2.959	0.016	0.013	0	57.2	59.3	64.1	160	165	0	27	27	
2025	4	9	8	33	9	0.771	-0.072	2.963	0.013	0.01	0	57.2	58.9	63.6	160	165	0	27	28	
2025	4	9	8	43	9	0.755	-0.03	2.966	0.016	0.013	0	57.2	58.9	64.1	160	165	0	27	28	
2025	4	9	8	53	9	0.794	-0.013	2.972	0.016	0.013	0	57.2	59.3	63.6	160	165	0	27	27	
2025	4	9	9	3	9	0.781	-0.049	2.976	0.016	0.013	0	56.8	58.9	64.5	160	164	0	28	27	
2025	4	9	9	13	9	0.804	-0.033	2.976	0.016	0.013	0	57.2	59.3	64.9	160	165	0	27	27	
2025	4	9	9	23	9	0.768	-0.046	2.979	0.016	0.013	0	57.2	58.9	64.9	160	165	0	27	28	
2025	4	9	9	33	9	0.83	-0.013	2.982	0.016	0.016	0	57.2	58.9	65.8	160	164	0	27	27	
2025	4	9	9	43	9	0.771	-0.03	2.982	0.013	0.01	0	57.2	58.9	65.8	160	165	0	27	28	
2025	4	9	9	53	9	0.807	-0.016	2.986	0.016	0.013	0	56.8	58.5	66.7	159	164	0	27	28	
2025	4	9	10	3	9	0.797	-0.039	2.986	0.013	0.01	0	56.8	58.9	67.1	160	165	0	28	28	
2025	4	9	10	13	9	0.81	-0.059	2.989	0.016	0.013	0	56.8	58.5	67.5	159	164	0	27	28	
2025	4	9	10	23	9	0.781	-0.069	2.992	0.016	0.013	0	57.2	58.9	67.5	160	164	0	27	27	
2025	4	9	10	33	9	0.797	-0.075	2.992	0.016	0.013	0	57.2	58.5	67.5	160	164	0	27	28	
2025	4	9	10	43	9	0.781	-0.052	2.992	0.016	0.013	0	57.2	58.9	67.1	160	165	0	27	28	
2025	4	9	10	53	9	0.801	-0.062	2.995	0.016	0.016	0	56.8	58.9	63.2	159	164	0	27	27	
2025	4	9	11	3	9	0.83	-0.03	2.995	0.016	0.016	0	57.2	58.9	47.7	160	164	0	27	27	
2025	4	9	11	13	9	0.807	-0.059	2.999	0.016	0.016	0	56.8	58.5	52.5	159	164	0	27	28	
2025	4	9	11	23	9	0.804	-0.036	2.999	0.016	0.016	0	56.8	59.3	48.6	160	165	0	28	27	
2025	4	9	11	33	9	0.85	-0.03	3.002	0.013	0.01	0	56.8	58.5	53.8	159	164	0	27	28	
2025	4	9	11	43	9	0.778	-0.069	3.002	0.016	0.013	0	57.6	58.5	60.6	160	164	0	26	28	
2025	4	9	11	53	9	0.843	-0.03	3.002	0.016	0.013	0	57.2	58.9	46.4	160	164	0	27	27	
2025	4	9	12	3	9	0.794	-0.03	3.005	0.016	0.013	0	57.2	58.5	45.6	159	164	0	26	28	
2025	4	9	12	13	9	0.81	-0.03	3.009	0.016	0.013	0	57.6	59.3	42.6	160	165	0	26	27	
2025	4	9	12	23	9	0.768	-0.016	3.009	0.016	0.013	0	57.2	58.9	49.5	160	165	0	27	28	
2025	4	9	12	33	9	0.804	-0.03	3.012	0.016	0.013	0	57.6	59.3	39.6	160	165	0	26	27	
2025	4	9	12	43	9	0.823	-0.046	3.012	0.013	0.01	0	58.5	58.9	42.6	162	164	0	26	27	
2025	4	9	12	53	9	0.82	-0.052	3.015	0.016	0.016	0	57.6	58.9	42.1	161	164	0	27	27	
2025	4	9	13	3	9	0.843	-0.043	3.018	0.016	0.013	0	57.6	59.3	62.8	161	165	0	27	27	
2025	4	9	13	13	9	0.814	-0.023	3.018	0.016	0.013	0	57.6	58.9	41.3	161	165	0	27	28	
2025	4	9	13	23	9	0.837	-0.01	3.022	0.016	0.013	0	58.5	58.9	39.6	162	165	0	26	28	
2025	4	9	13	33	9	0.81	-0.046	3.025	0.016	0.013	0	57.6	59.3	42.1	161	165	0	27	27	
2025	4	9	13	43	9	0.814	-0.013	3.025	0.016	0.013	0	58	59.3	41.7	161	165	0	26	27	
2025	4	9	13	53	9	0.84	-0.036	3.028	0.016	0.013	0	57.6	59.3	39.1	161	165	0	27	27	
2025	4	9	14	3	9	0.807	0	3.031	0.016	0.013	0	58	58.9	40.9	161	165	0	26	28	
2025	4	9	14	13	9	0.833	-0.02	3.031	0.016	0.013	0	57.6	59.3	38.7	161	165	0	27	27	
2025	4	9	14	23	9	0.84	-0.03	3.035	0.013	0.01	0	58.5	59.8	37.8	162	165	0	26	26	
2025	4	9	14	33	9	0.843	-0.02	3.035	0.016	0.016	0	57.6	58.9	37.8	161	164	0	27	27	
2025	4	9	14	43	9	0.863	-0.039	3.038	0.016	0.013	0	58	59.3	40.4	161	165	0	26	27	
2025	4	9	14	53	9	0.866	-0.036	3.041	0.016	0.016	0	58	58.9	38.7	161	164	0	26	27	
2025	4	9	15	3	9	0.833	-0.046	3.045	0.016	0.013	0	58	59.3	43.4	162	165	0	27	27	
2025	4	9	15	13	9	0.833	-0.03	3.045	0.016	0.013	0	58.5	58.9	39.6	162	165	0	26	28	
2025	4	9	15	23	9	0.86	-0.013	3.048	0.016	0.013	0	58	59.3	40	161	165	0	26	27	
2025	4	9	15	33	9	0.866	-0.039	3.051	0.016	0.013	0	58	59.3	40.9	161	165	0	26	27	
2025	4	9	15	43	9	0.853	-0.039	3.051	0.016	0.013	0	57.6	58.9	39.1	161	164	0	27	27	
2025	4	9	15	53	9	0.856	-0.026	3.051	0.013	0.01	0	58	59.3	40.9	161	165	0	26	27	

Mazourka (0354)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	
2025	4	9	16	3	9	0.873	-0.052	3.054	0.016	0.016	0	58	59.3	39.1	161	165	0	26	27	
2025	4	9	16	13	9	0.846	-0.043	3.054	0.016	0.013	0	58	59.3	39.1	162	165	0	27	27	
2025	4	9	16	23	9	0.846	-0.02	3.054	0.016	0.013	0	58	59.8	38.3	162	165	0	27	26	
2025	4	9	16	33	9	0.791	0	3.061	0.016	0.016	0	58.5	59.8	42.1	162	166	0	26	27	
2025	4	9	16	43	9	0.86	-0.013	3.061	0.016	0.013	0	58.5	60.2	41.3	162	166	0	26	26	
2025	4	9	16	53	9	0.84	-0.043	3.064	0.016	0.013	0	58.5	59.8	40	162	165	0	26	26	
2025	4	9	17	3	9	0.856	-0.052	3.064	0.016	0.013	0	58	59.3	40.4	161	165	0	26	27	
2025	4	9	17	13	9	0.843	-0.046	3.064	0.016	0.013	0	58	58.9	39.6	161	164	0	26	27	
2025	4	9	17	23	9	0.82	-0.043	3.064	0.02	0.016	0	58	58.9	42.6	161	165	0	26	28	
2025	4	9	17	33	9	0.889	-0.069	3.064	0.016	0.016	0	58	59.3	47.7	161	164	0	26	26	
2025	4	9	17	43	9	0.853	-0.013	3.064	0.016	0.013	0	58	59.3	53.3	161	165	0	26	27	
2025	4	9	17	53	9	0.863	-0.003	3.068	0.016	0.016	0	57.2	58.9	61.1	160	164	0	27	27	
2025	4	9	18	3	9	0.85	-0.033	3.068	0.016	0.013	0	57.6	58.5	60.2	160	163	0	26	27	
2025	4	9	18	13	9	0.866	-0.016	3.074	0.016	0.013	0	57.6	58.9	38.3	160	163	0	26	26	
2025	4	9	18	23	9	0.889	-0.03	3.074	0.016	0.013	0	57.6	58.9	40.9	160	164	0	26	27	
2025	4	9	18	33	9	0.846	-0.043	3.074	0.016	0.016	0	57.6	58.9	40.9	160	164	0	26	27	
2025	4	9	18	43	9	0.84	-0.052	3.077	0.016	0.016	0	58	58.9	42.1	161	164	0	26	27	
2025	4	9	18	53	9	0.853	0	3.081	0.02	0.016	0	57.2	58.9	41.3	160	164	0	27	27	
2025	4	9	19	3	9	0.837	-0.03	3.081	0.016	0.013	0	57.6	58.9	41.3	160	164	0	26	27	
2025	4	9	19	13	9	0.846	-0.01	3.084	0.013	0.01	0	58	59.3	39.6	161	164	0	26	26	
2025	4	9	19	23	9	0.846	0	3.087	0.016	0.016	0	57.2	58.9	47.7	160	164	0	27	27	
2025	4	9	19	33	9	0.876	-0.016	3.087	0.013	0.01	0	57.6	58.9	45.6	160	164	0	26	27	
2025	4	9	19	43	9	0.866	-0.036	3.087	0.016	0.013	0	57.6	58.9	41.3	160	164	0	26	27	
2025	4	9	19	53	9	0.843	-0.046	3.091	0.016	0.013	0	57.6	59.3	65.8	161	164	0	27	26	
2025	4	9	20	3	9	0.869	-0.03	3.091	0.02	0.016	0	58	58.9	66.7	161	164	0	26	27	
2025	4	9	20	13	9	0.837	-0.016	3.094	0.016	0.013	0	57.6	58.9	66.2	160	164	0	26	27	
2025	4	9	20	23	9	0.883	-0.043	3.094	0.016	0.013	0	57.6	59.3	65.8	160	164	0	26	26	
2025	4	9	20	33	9	0.876	-0.036	3.094	0.01	0.007	0	58	59.3	65.8	161	164	0	26	26	
2025	4	9	20	43	9	0.833	0.003	3.094	0.016	0.016	0	58	59.3	65.4	161	164	0	26	26	
2025	4	9	20	53	9	0.876	-0.016	3.094	0.016	0.013	0	57.6	58.9	65.8	160	164	0	26	27	
2025	4	9	21	3	9	0.853	-0.046	3.094	0.016	0.016	0	57.2	58.5	65.8	160	164	0	27	28	
2025	4	9	21	13	9	0.856	-0.036	3.097	0.016	0.016	0	58	58.9	65.4	161	164	0	26	27	
2025	4	9	21	23	9	0.856	-0.03	3.097	0.016	0.013	0	57.6	58.9	64.9	160	164	0	26	27	
2025	4	9	21	33	9	0.814	-0.039	3.097	0.013	0.01	0	57.6	58.5	64.5	160	164	0	26	28	
2025	4	9	21	43	9	0.86	-0.026	3.097	0.016	0.016	0	57.6	58.9	64.1	161	164	0	27	27	
2025	4	9	21	53	9	0.909	-0.046	3.097	0.013	0.01	0	57.6	58.9	64.1	160	164	0	26	27	
2025	4	9	22	3	9	0.876	-0.02	3.1	0.013	0.01	0	57.6	58.9	63.6	160	164	0	26	27	
2025	4	9	22	13	9	0.876	0.003	3.1	0.016	0.013	0	57.2	58.9	63.6	160	164	0	27	27	
2025	4	9	22	23	9	0.853	-0.03	3.104	0.016	0.013	0	57.6	59.3	63.6	161	164	0	27	26	
2025	4	9	22	33	9	0.879	-0.016	3.107	0.016	0.013	0	57.6	58.9	62.8	160	164	0	26	27	
2025	4	9	22	43	9	0.889	-0.046	3.114	0.016	0.013	0	57.6	58.9	63.6	160	164	0	26	27	
2025	4	9	22	53	9	0.866	-0.026	3.114	0.016	0.016	0	58	59.8	63.2	161	165	0	26	26	
2025	4	9	23	3	9	0.863	-0.023	3.114	0.016	0.013	0	58	59.3	63.6	161	164	0	26	26	
2025	4	9	23	13	9	0.863	-0.023	3.114	0.016	0.013	0	57.6	58.9	64.5	160	164	0	26	27	
2025	4	9	23	23	9	0.833	-0.062	3.117	0.016	0.013	0	57.2	58.9	64.5	160	164	0	27	27	
2025	4	9	23	33	9	0.909	-0.016	3.117	0.016	0.016	0	57.6	58.9	65.4	160	164	0	26	27	
2025	4	9	23	43	9	0.856	-0.023	3.117	0.01	0.007	0	58	59.3	65.8	161	165	0	26	27	
2025	4	9	23	53	9	0.863	-0.046	3.117	0.013	0.01	0	57.6	58.9	66.2	161	164	0	27	27	

Mazourka (0354)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	
2025	4	10	0	3	9	0.837	-0.052	3.117	0.016	0.013	0	57.6	59.3	66.7	161	165	0	27	27	
2025	4	10	0	13	9	0.879	-0.036	3.12	0.016	0.013	0	57.6	58.9	66.2	161	164	0	27	27	
2025	4	10	0	23	9	0.915	-0.03	3.12	0.016	0.013	0	57.6	59.3	67.1	160	164	0	26	26	
2025	4	10	0	33	9	0.86	-0.033	3.12	0.016	0.016	0	57.2	58.5	66.2	160	164	0	27	28	
2025	4	10	0	43	9	0.902	-0.033	3.12	0.016	0.013	0	57.2	58.9	67.1	160	164	0	27	27	
2025	4	10	0	53	9	0.879	-0.02	3.12	0.02	0.016	0	58	59.3	66.7	161	165	0	26	27	
2025	4	10	1	3	9	0.896	-0.043	3.12	0.016	0.013	0	57.2	58.9	66.7	160	164	0	27	27	
2025	4	10	1	13	9	0.83	-0.036	3.12	0.016	0.013	0	58	59.3	66.2	161	165	0	26	27	
2025	4	10	1	23	9	0.866	-0.013	3.12	0.016	0.013	0	57.6	58.9	66.2	161	164	0	27	27	
2025	4	10	1	33	9	0.899	-0.03	3.12	0.016	0.013	0	57.6	58.9	66.2	161	164	0	27	27	
2025	4	10	1	43	9	0.886	-0.03	3.12	0.016	0.013	0	57.6	59.3	63.6	161	165	0	27	27	
2025	4	10	1	53	9	0.869	-0.026	3.12	0.016	0.013	0	57.6	59.3	65.4	161	165	0	27	27	
2025	4	10	2	3	9	0.869	-0.033	3.12	0.016	0.013	0	58	59.3	65.4	161	165	0	26	27	
2025	4	10	2	13	9	0.902	-0.039	3.12	0.016	0.013	0	57.2	59.3	64.9	160	165	0	27	27	
2025	4	10	2	23	9	0.856	-0.043	3.12	0.013	0.01	0	57.6	58.9	64.9	161	165	0	27	28	
2025	4	10	2	33	9	0.883	-0.016	3.123	0.016	0.016	0	57.6	58.9	64.9	161	165	0	27	28	
2025	4	10	2	43	9	0.863	-0.016	3.123	0.016	0.013	0	57.6	59.3	64.9	161	165	0	27	27	
2025	4	10	2	53	9	0.869	0	3.123	0.016	0.013	0	58	59.8	64.1	161	165	0	26	26	
2025	4	10	3	3	9	0.863	-0.02	3.123	0.016	0.013	0	57.6	59.3	64.5	161	165	0	27	27	
2025	4	10	3	13	9	0.869	-0.033	3.123	0.016	0.016	0	57.6	59.3	63.6	161	165	0	27	27	
2025	4	10	3	23	9	0.863	-0.013	3.123	0.013	0.01	0	57.6	58.9	63.6	161	165	0	27	28	
2025	4	10	3	33	9	0.869	-0.007	3.123	0.016	0.013	0	58	58.9	63.6	161	165	0	26	28	
2025	4	10	3	43	9	0.906	-0.052	3.123	0.016	0.016	0	58	58.9	62.8	162	165	0	27	28	
2025	4	10	3	53	9	0.866	-0.069	3.127	0.016	0.013	0	58	59.3	62.8	162	165	0	27	27	
2025	4	10	4	3	9	0.866	-0.016	3.127	0.016	0.013	0	57.6	58.5	62.8	161	164	0	27	28	
2025	4	10	4	13	9	0.853	-0.023	3.127	0.016	0.013	0	58	59.3	62.4	162	165	0	27	27	
2025	4	10	4	23	9	0.873	-0.016	3.13	0.016	0.013	0	58	59.8	62.8	162	165	0	27	26	
2025	4	10	4	33	9	0.896	-0.03	3.136	0.016	0.013	0	57.6	58.5	63.2	161	164	0	27	28	
2025	4	10	4	43	9	0.899	0.01	3.136	0.016	0.013	0	58.5	58.9	63.2	162	165	0	26	28	
2025	4	10	4	53	9	0.853	-0.043	3.14	0.016	0.016	0	58	58.9	62.8	162	165	0	27	28	
2025	4	10	5	3	9	0.843	-0.03	3.14	0.016	0.016	0	58	59.3	63.2	162	165	0	27	27	
2025	4	10	5	13	9	0.873	-0.003	3.14	0.013	0.01	0	57.6	58.9	63.2	162	165	0	28	28	
2025	4	10	5	23	9	0.899	-0.069	3.14	0.016	0.016	0	58	59.8	63.2	162	166	0	27	27	
2025	4	10	5	33	9	0.886	-0.016	3.14	0.016	0.013	0	58	59.8	64.1	162	165	0	27	26	
2025	4	10	5	43	9	0.856	-0.03	3.14	0.016	0.013	0	58	59.3	64.5	162	165	0	27	27	
2025	4	10	5	53	9	0.873	-0.013	3.14	0.013	0.01	0	58	59.3	64.5	162	165	0	27	27	
2025	4	10	6	3	9	0.863	-0.039	3.143	0.016	0.013	0	58	59.3	64.9	162	165	0	27	27	
2025	4	10	6	13	9	0.863	-0.016	3.143	0.01	0.007	0	58	58.9	64.9	162	165	0	27	28	
2025	4	10	6	23	9	0.876	-0.052	3.143	0.013	0.01	0	58	59.3	64.9	162	165	0	27	27	
2025	4	10	6	33	9	0.863	-0.033	3.143	0.016	0.013	0	58.5	59.8	65.4	163	166	0	27	27	
2025	4	10	6	43	9	0.886	-0.033	3.143	0.013	0.01	0	58	59.3	65.4	162	166	0	27	28	
2025	4	10	6	53	9	0.863	-0.043	3.143	0.013	0.01	0	58.5	59.3	65.8	163	166	0	27	28	
2025	4	10	7	3	9	0.886	-0.059	3.143	0.01	0.007	0	58.5	59.8	65.4	163	166	0	27	27	
2025	4	10	7	13	9	0.919	-0.02	3.143	0.016	0.016	0	58	59.3	66.2	162	166	0	27	28	
2025	4	10	7	23	9	0.928	-0.01	3.143	0.013	0.01	0	58.5	59.3	66.2	162	165	0	26	27	
2025	4	10	7	33	9	0.869	-0.007	3.143	0.016	0.016	0	58	59.8	66.2	162	166	0	27	27	
2025	4	10	7	43	9	0.876	-0.043	3.143	0.016	0.013	0	58.5	59.8	65.8	163	166	0	27	27	
2025	4	10	7	53	9	0.902	-0.016	3.143	0.013	0.01	0	58	59.8	65.8	162	166	0	27	27	

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	10	8	3	9	0.883	-0.026	3.146	0.016	0.013	0	58.9	59.3	65.8	163	166	0	26	28
2025	4	10	8	13	9	0.886	-0.007	3.146	0.016	0.013	0	58	59.3	66.2	162	166	0	27	28
2025	4	10	8	23	9	0.85	-0.013	3.146	0.016	0.016	0	58	59.3	66.7	162	166	0	27	28
2025	4	10	8	33	9	0.896	-0.007	3.146	0.016	0.013	0	58	59.8	66.7	162	166	0	27	27
2025	4	10	8	43	9	0.902	-0.016	3.146	0.016	0.013	0	58.5	58.9	66.2	162	165	0	26	28
2025	4	10	8	53	9	0.906	-0.043	3.146	0.016	0.013	0	58	59.8	66.2	162	166	0	27	27
2025	4	10	9	3	9	0.876	-0.02	3.146	0.016	0.013	0	58	59.3	66.2	162	165	0	27	27
2025	4	10	9	13	9	0.892	-0.016	3.15	0.02	0.016	0	58	59.3	66.7	162	165	0	27	27
2025	4	10	9	23	9	0.827	-0.049	3.15	0.016	0.013	0	58	59.8	66.2	162	166	0	27	27
2025	4	10	9	33	9	0.902	0	3.15	0.016	0.013	0	58	58.9	63.2	162	165	0	27	28
2025	4	10	9	43	9	0.925	-0.056	3.15	0.016	0.016	0	57.6	58.9	65.8	161	164	0	27	27
2025	4	10	9	53	9	0.889	-0.046	3.15	0.016	0.013	0	58	59.3	65.8	162	165	0	27	27
2025	4	10	10	3	9	0.912	-0.046	3.15	0.016	0.013	0	58.5	59.3	63.6	162	165	0	26	27
2025	4	10	10	13	9	0.886	-0.016	3.15	0.016	0.013	0	58	59.3	51.6	161	165	0	26	27
2025	4	10	10	23	9	0.935	-0.056	3.146	0.016	0.013	0	57.6	59.3	40	161	165	0	27	27
2025	4	10	10	33	9	0.886	-0.026	3.146	0.013	0.01	0	57.6	59.3	42.1	161	165	0	27	27
2025	4	10	10	43	9	0.896	-0.01	3.15	0.016	0.013	0	57.6	59.3	46.4	161	165	0	27	27
2025	4	10	10	53	9	0.935	-0.013	3.15	0.016	0.016	0	58	59.3	45.6	161	165	0	26	27
2025	4	10	11	3	9	0.879	-0.016	3.146	0.016	0.013	0	57.6	59.3	38.7	161	165	0	27	27
2025	4	10	11	13	9	0.899	-0.066	3.146	0.016	0.013	0	57.6	59.8	37.8	161	165	0	27	26
2025	4	10	11	23	9	0.886	-0.02	3.15	0.013	0.01	0	57.6	59.3	40.4	161	165	0	27	27
2025	4	10	11	33	9	0.886	-0.03	3.15	0.013	0.01	0	58	59.3	38.3	161	165	0	26	27
2025	4	10	11	43	9	0.889	-0.039	3.146	0.013	0.01	0	57.6	59.3	38.7	161	165	0	27	27
2025	4	10	11	53	9	0.899	-0.01	3.153	0.016	0.016	0	58.5	59.3	38.3	162	165	0	26	27
2025	4	10	12	3	9	0.896	0	3.146	0.016	0.013	0	57.6	59.3	37.8	161	165	0	27	27
2025	4	10	12	13	9	0.889	-0.056	3.146	0.016	0.013	0	57.6	58.9	36.5	161	165	0	27	28
2025	4	10	12	23	9	0.935	-0.052	3.15	0.016	0.016	0	57.6	59.3	38.7	161	165	0	27	27
2025	4	10	12	33	9	0.892	-0.03	3.15	0.016	0.013	0	58.5	60.2	39.6	162	166	0	26	26
2025	4	10	12	43	9	0.919	-0.023	3.153	0.016	0.016	0	58	59.3	39.1	161	165	0	26	27
2025	4	10	12	53	9	0.899	-0.03	3.15	0.016	0.016	0	58.5	59.3	38.7	162	165	0	26	27
2025	4	10	13	3	9	0.906	-0.02	3.15	0.016	0.013	0	58.5	58.9	39.6	162	165	0	26	28
2025	4	10	13	13	9	0.915	-0.03	3.153	0.016	0.016	0	57.6	59.3	36.5	161	165	0	27	27
2025	4	10	13	23	9	0.896	0	3.153	0.016	0.013	0	58	59.8	38.3	161	165	0	26	26
2025	4	10	13	33	9	0.906	-0.016	3.15	0.016	0.013	0	57.6	59.3	36.5	161	165	0	27	27
2025	4	10	13	43	9	0.912	-0.072	3.153	0.016	0.013	0	57.6	59.3	39.6	160	164	0	26	26
2025	4	10	13	53	9	0.938	-0.013	3.153	0.016	0.013	0	57.6	58.9	39.6	160	164	0	26	27
2025	4	10	14	3	9	0.919	-0.007	3.156	0.016	0.013	0	58	59.3	40	161	165	0	26	27
2025	4	10	14	13	9	0.915	-0.052	3.159	0.016	0.013	0	58	59.3	40.4	161	165	0	26	27
2025	4	10	14	23	9	0.945	-0.02	3.153	0.016	0.013	0	57.6	58.9	37.8	160	164	0	26	27
2025	4	10	14	33	9	0.886	-0.043	3.156	0.016	0.016	0	58	59.3	39.6	161	165	0	26	27
2025	4	10	14	43	9	0.902	-0.003	3.156	0.016	0.016	0	57.6	58.9	40.4	160	164	0	26	27
2025	4	10	14	53	9	0.899	-0.016	3.156	0.016	0.016	0	57.6	59.3	38.7	160	165	0	26	27
2025	4	10	15	3	9	0.889	-0.016	3.163	0.016	0.016	0	57.6	59.3	39.6	160	165	0	26	27
2025	4	10	15	13	9	0.879	-0.026	3.156	0.013	0.01	0	57.2	59.3	40	160	164	0	27	26
2025	4	10	15	23	9	0.896	-0.02	3.163	0.016	0.013	0	57.6	59.3	38.3	160	164	0	26	26
2025	4	10	15	33	9	0.922	-0.036	3.156	0.016	0.016	0	57.2	58.9	37.4	160	164	0	27	27
2025	4	10	15	43	9	0.942	-0.03	3.163	0.016	0.013	0	57.6	59.3	37.8	160	164	0	26	26
2025	4	10	15	53	9	0.928	-0.02	3.159	0.01	0.007	0	57.2	58.9	39.6	160	164	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	10	16	3	9	0.883	-0.023	3.163	0.016	0.013	0	58	58.9	39.6	160	164	0	25	27
2025	4	10	16	13	9	0.889	-0.013	3.163	0.016	0.016	0	57.6	58.9	41.3	160	164	0	26	27
2025	4	10	16	23	9	0.928	-0.069	3.163	0.016	0.016	0	57.6	58.9	38.7	160	164	0	26	27
2025	4	10	16	33	9	0.886	-0.02	3.163	0.016	0.013	0	57.6	59.8	41.7	160	165	0	26	26
2025	4	10	16	43	9	0.912	-0.046	3.159	0.016	0.016	0	57.6	58.9	39.1	160	164	0	26	27
2025	4	10	16	53	9	0.915	-0.016	3.163	0.016	0.013	0	57.6	58.9	39.1	160	164	0	26	27
2025	4	10	17	3	9	0.906	-0.007	3.166	0.016	0.013	0	57.6	59.3	40	160	164	0	26	26
2025	4	10	17	13	9	0.928	0.01	3.166	0.016	0.013	0	57.6	58.9	44.3	160	164	0	26	27
2025	4	10	17	23	9	0.919	-0.013	3.166	0.016	0.013	0	57.6	58.9	41.3	159	164	0	25	27
2025	4	10	17	33	9	0.889	-0.033	3.166	0.016	0.013	0	57.6	59.3	38.7	160	164	0	26	26
2025	4	10	17	43	9	0.919	-0.039	3.169	0.02	0.016	0	56.8	58.5	49	159	163	0	27	27
2025	4	10	17	53	9	0.892	-0.056	3.169	0.016	0.013	0	57.2	58.9	51.6	159	164	0	26	27
2025	4	10	18	3	9	0.945	0	3.173	0.013	0.01	0	57.6	58.5	65.8	160	163	0	26	27
2025	4	10	18	13	9	0.896	-0.026	3.173	0.013	0.01	0	57.6	58.9	62.4	160	164	0	26	27
2025	4	10	18	23	9	0.922	0.003	3.173	0.013	0.01	0	57.6	58.9	66.2	160	164	0	26	27
2025	4	10	18	33	9	0.945	-0.046	3.173	0.016	0.013	0	57.2	58.9	66.7	159	164	0	26	27
2025	4	10	18	43	9	0.879	-0.003	3.173	0.016	0.013	0	57.6	59.3	66.2	160	164	0	26	26
2025	4	10	18	53	9	0.873	-0.016	3.173	0.016	0.016	0	57.2	58.9	66.7	160	164	0	27	27
2025	4	10	19	3	9	0.922	-0.052	3.176	0.013	0.01	0	57.6	59.3	66.7	160	164	0	26	26
2025	4	10	19	13	9	0.886	-0.069	3.173	0.016	0.013	0	57.6	59.3	66.7	160	164	0	26	26
2025	4	10	19	23	9	0.928	-0.043	3.173	0.016	0.013	0	57.6	58.9	66.7	160	164	0	26	27
2025	4	10	19	33	9	0.919	-0.039	3.173	0.016	0.016	0	57.6	59.3	66.7	160	164	0	26	26
2025	4	10	19	43	9	0.899	-0.023	3.173	0.013	0.01	0	57.6	58.9	63.6	160	164	0	26	27
2025	4	10	19	53	9	0.915	-0.03	3.173	0.013	0.01	0	57.2	58.9	66.7	159	163	0	26	26
2025	4	10	20	3	9	0.863	0	3.173	0.016	0.016	0	57.6	58.9	65.8	160	164	0	26	27
2025	4	10	20	13	9	0.909	0	3.173	0.016	0.013	0	57.6	58.9	66.2	160	164	0	26	27
2025	4	10	20	23	9	0.915	-0.052	3.173	0.016	0.013	0	57.6	58.9	67.1	160	164	0	26	27
2025	4	10	20	33	9	0.866	-0.039	3.173	0.016	0.016	0	57.6	58.9	66.7	160	164	0	26	27
2025	4	10	20	43	9	0.902	0	3.173	0.016	0.013	0	57.6	58.9	66.2	160	164	0	26	27
2025	4	10	20	53	9	0.925	-0.013	3.173	0.013	0.01	0	57.6	58.9	66.7	160	164	0	26	27
2025	4	10	21	3	9	0.925	-0.013	3.173	0.016	0.016	0	57.2	59.3	66.2	160	164	0	27	26
2025	4	10	21	13	9	0.892	-0.02	3.173	0.013	0.01	0	57.6	58.9	65.8	160	164	0	26	27
2025	4	10	21	23	9	0.892	-0.016	3.173	0.013	0.01	0	57.2	58.9	66.7	160	164	0	27	27
2025	4	10	21	33	9	0.938	-0.026	3.173	0.02	0.016	0	57.6	58.9	65.8	160	164	0	26	27
2025	4	10	21	43	9	0.912	-0.03	3.173	0.016	0.013	0	57.6	58.9	66.2	160	164	0	26	27
2025	4	10	21	53	9	0.902	-0.007	3.173	0.016	0.013	0	57.6	58.9	65.8	160	164	0	26	27
2025	4	10	22	3	9	0.906	-0.043	3.173	0.016	0.016	0	58	58.9	65.8	161	164	0	26	27
2025	4	10	22	13	9	0.892	-0.003	3.173	0.016	0.013	0	57.6	58.9	66.2	160	164	0	26	27
2025	4	10	22	23	9	0.899	-0.036	3.173	0.013	0.01	0	57.2	58.9	65.4	160	164	0	27	27
2025	4	10	22	33	9	0.889	-0.052	3.173	0.016	0.013	0	57.2	59.3	65.4	160	165	0	27	27
2025	4	10	22	43	9	0.902	-0.007	3.173	0.016	0.013	0	58	59.3	65.4	161	165	0	26	27
2025	4	10	22	53	9	0.922	0	3.173	0.02	0.016	0	57.6	58.9	65.4	160	164	0	26	27
2025	4	10	23	3	9	0.899	-0.02	3.173	0.016	0.013	0	57.6	58.5	65.4	160	164	0	26	28
2025	4	10	23	13	9	0.909	-0.01	3.173	0.013	0.01	0	58	59.3	65.4	161	165	0	26	27
2025	4	10	23	23	9	0.915	-0.046	3.169	0.016	0.013	0	58	59.3	65.4	161	165	0	26	27
2025	4	10	23	33	9	0.892	-0.03	3.169	0.016	0.013	0	57.6	59.3	65.4	161	165	0	27	27
2025	4	10	23	43	9	0.915	-0.023	3.169	0.016	0.016	0	57.6	59.3	64.9	160	164	0	26	26
2025	4	10	23	53	9	0.928	-0.046	3.169	0.016	0.013	0	57.6	59.3	64.5	160	164	0	26	26

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	11	0	3	9	0.928	-0.046	3.169	0.016	0.013	0	57.2	58.9	64.9	160	164	0	27	27
2025	4	11	0	13	9	0.883	-0.01	3.169	0.016	0.013	0	57.2	58.9	61.9	160	164	0	27	27
2025	4	11	0	23	9	0.909	0.02	3.169	0.016	0.016	0	57.2	58.9	64.9	160	164	0	27	27
2025	4	11	0	33	9	0.896	-0.03	3.169	0.016	0.016	0	57.2	58.9	62.4	160	164	0	27	27
2025	4	11	0	43	9	0.909	-0.03	3.169	0.013	0.01	0	57.2	58.9	64.5	160	164	0	27	27
2025	4	11	0	53	9	0.879	-0.03	3.169	0.016	0.013	0	57.6	58.9	64.5	160	164	0	26	27
2025	4	11	1	3	9	0.906	-0.016	3.169	0.016	0.016	0	57.2	58.9	53.8	160	164	0	27	27
2025	4	11	1	13	9	0.919	-0.026	3.169	0.02	0.016	0	57.2	59.3	63.6	160	164	0	27	26
2025	4	11	1	23	9	0.922	-0.033	3.169	0.016	0.016	0	57.6	58.5	63.2	161	164	0	27	28
2025	4	11	1	33	9	0.922	-0.039	3.169	0.016	0.013	0	58	58.5	63.2	161	164	0	26	28
2025	4	11	1	43	9	0.892	-0.03	3.169	0.016	0.016	0	57.6	58.9	63.6	161	164	0	27	27
2025	4	11	1	53	9	0.892	-0.046	3.169	0.016	0.013	0	57.6	58.9	63.6	161	164	0	27	27
2025	4	11	2	3	9	0.919	-0.039	3.169	0.016	0.016	0	57.6	58.9	63.6	161	164	0	27	27
2025	4	11	2	13	9	0.889	-0.02	3.169	0.016	0.013	0	57.6	58.9	63.2	161	164	0	27	27
2025	4	11	2	23	9	0.909	0	3.173	0.013	0.01	0	57.6	58.9	62.4	161	164	0	27	27
2025	4	11	2	33	9	0.879	-0.01	3.173	0.01	0.007	0	58	58.5	62.8	161	164	0	26	28
2025	4	11	2	43	9	0.883	-0.007	3.173	0.016	0.013	0	57.6	58.9	62.4	161	164	0	27	27
2025	4	11	2	53	9	0.942	-0.03	3.173	0.016	0.013	0	57.6	58.9	62.8	161	164	0	27	27
2025	4	11	3	3	9	0.928	-0.036	3.176	0.016	0.013	0	57.6	59.3	62.8	161	165	0	27	27
2025	4	11	3	13	9	0.889	-0.01	3.176	0.016	0.016	0	57.6	58.9	62.8	161	164	0	27	27
2025	4	11	3	23	9	0.906	-0.01	3.179	0.016	0.013	0	58	58.5	62.8	161	164	0	26	28
2025	4	11	3	33	9	0.932	0	3.179	0.013	0.01	0	57.6	58.9	62.8	161	164	0	27	27
2025	4	11	3	43	9	0.915	-0.013	3.179	0.013	0.01	0	58.5	59.3	57.6	162	165	0	26	27
2025	4	11	3	53	9	0.928	-0.03	3.179	0.016	0.013	0	57.6	58.9	56.8	161	165	0	27	28
2025	4	11	4	3	9	0.879	-0.02	3.182	0.016	0.016	0	58	58.9	63.2	162	165	0	27	28
2025	4	11	4	13	9	0.915	-0.043	3.179	0.013	0.01	0	57.6	59.3	56.3	161	165	0	27	27
2025	4	11	4	23	9	0.873	-0.016	3.179	0.016	0.013	0	58.5	59.8	51.2	163	166	0	27	27
2025	4	11	4	33	9	0.896	-0.043	3.182	0.016	0.016	0	58	59.3	62.4	162	165	0	27	27
2025	4	11	4	43	9	0.902	-0.016	3.182	0.013	0.01	0	58	59.3	63.2	161	165	0	26	27
2025	4	11	4	53	9	0.899	-0.02	3.182	0.016	0.013	0	58	58.9	63.6	162	165	0	27	28
2025	4	11	5	3	9	0.896	-0.043	3.186	0.016	0.016	0	58.5	59.8	63.6	162	165	0	26	26
2025	4	11	5	13	9	0.971	-0.016	3.186	0.016	0.016	0	57.6	59.3	64.5	161	165	0	27	27
2025	4	11	5	23	9	0.886	-0.056	3.182	0.013	0.01	0	58	59.3	64.1	162	165	0	27	27
2025	4	11	5	33	9	0.925	-0.023	3.186	0.016	0.013	0	58	59.3	64.1	162	165	0	27	27
2025	4	11	5	43	9	0.925	-0.052	3.182	0.013	0.01	0	58	59.3	64.1	162	165	0	27	27
2025	4	11	5	53	9	0.915	-0.043	3.186	0.016	0.013	0	58	58.9	64.5	162	165	0	27	28
2025	4	11	6	3	9	0.909	-0.03	3.186	0.016	0.013	0	58	59.3	64.1	162	165	0	27	27
2025	4	11	6	13	9	0.919	-0.049	3.186	0.016	0.013	0	58	58.9	64.5	162	165	0	27	28
2025	4	11	6	23	9	0.889	-0.016	3.186	0.016	0.013	0	58	59.8	64.9	162	166	0	27	27
2025	4	11	6	33	9	0.892	-0.023	3.182	0.016	0.013	0	58	59.3	65.4	162	165	0	27	27
2025	4	11	6	43	9	0.889	-0.03	3.182	0.016	0.016	0	58.9	59.8	65.4	163	166	0	26	27
2025	4	11	6	53	9	0.889	-0.036	3.186	0.016	0.013	0	58.5	59.8	65.4	163	166	0	27	27
2025	4	11	7	3	9	0.876	-0.039	3.186	0.016	0.013	0	58.5	59.3	64.9	163	166	0	27	28
2025	4	11	7	13	9	0.932	-0.043	3.186	0.016	0.013	0	58	59.8	65.4	162	166	0	27	27
2025	4	11	7	23	9	0.909	-0.033	3.186	0.02	0.016	0	58.9	59.8	65.4	163	166	0	26	27
2025	4	11	7	33	9	0.932	-0.059	3.186	0.016	0.016	0	58	59.3	64.9	162	165	0	27	27
2025	4	11	7	43	9	0.869	-0.03	3.182	0.016	0.013	0	58	59.3	63.2	163	166	0	28	28
2025	4	11	7	53	9	0.886	-0.039	3.186	0.013	0.01	0	58	59.3	64.9	162	166	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	11	8	3	9	0.889	-0.026	3.186	0.013	0.01	0	58	59.3	64.9	162	166	0	27	28
2025	4	11	8	13	9	0.925	-0.007	3.186	0.016	0.013	0	58.5	59.8	64.5	163	166	0	27	27
2025	4	11	8	23	9	0.925	-0.026	3.186	0.016	0.013	0	58	59.8	64.9	162	166	0	27	27
2025	4	11	8	33	9	0.912	-0.039	3.186	0.016	0.016	0	58.9	59.8	64.5	163	166	0	26	27
2025	4	11	8	43	9	0.902	-0.059	3.186	0.013	0.01	0	58	59.8	63.6	162	166	0	27	27
2025	4	11	8	53	9	0.919	-0.033	3.186	0.016	0.013	0	58.5	59.8	64.1	163	166	0	27	27
2025	4	11	9	3	9	0.883	-0.033	3.186	0.016	0.016	0	58.5	60.2	64.1	163	166	0	27	26
2025	4	11	9	13	9	0.899	0	3.186	0.016	0.016	0	58.5	59.8	64.5	163	166	0	27	27
2025	4	11	9	23	9	0.886	0	3.186	0.013	0.01	0	58.5	59.8	63.6	163	166	0	27	27
2025	4	11	9	33	9	0.896	-0.03	3.186	0.016	0.013	0	58.5	59.3	63.6	163	166	0	27	28
2025	4	11	9	43	9	0.912	-0.02	3.186	0.013	0.01	0	58	59.8	61.9	162	166	0	27	27
2025	4	11	9	53	9	0.876	-0.036	3.186	0.016	0.016	0	58.9	60.2	62.8	164	167	0	27	27
2025	4	11	10	3	9	0.889	-0.033	3.182	0.016	0.013	0	58.5	60.2	57.2	163	167	0	27	27
2025	4	11	10	13	9	0.879	-0.02	3.179	0.013	0.01	0	58.5	59.3	48.2	163	166	0	27	28
2025	4	11	10	23	9	0.879	0	3.179	0.013	0.01	0	58.9	59.8	49.9	163	166	0	26	27
2025	4	11	10	33	9	0.925	-0.033	3.179	0.013	0.01	0	58	59.8	50.3	162	166	0	27	27
2025	4	11	10	43	9	0.925	-0.049	3.179	0.016	0.016	0	58.5	59.8	60.2	162	166	0	26	27
2025	4	11	10	53	9	0.925	-0.049	3.176	0.013	0.01	0	58.5	59.8	48.2	162	166	0	26	27
2025	4	11	11	3	9	0.928	-0.01	3.179	0.013	0.01	0	58	58.9	38.7	162	165	0	27	28
2025	4	11	11	13	9	0.938	-0.03	3.182	0.016	0.016	0	58.9	59.8	42.6	163	166	0	26	27
2025	4	11	11	23	9	0.922	-0.013	3.176	0.016	0.013	0	58	59.8	43.4	162	166	0	27	27
2025	4	11	11	33	9	0.906	-0.059	3.176	0.02	0.016	0	58	59.3	40	162	165	0	27	27
2025	4	11	11	43	9	0.925	-0.03	3.179	0.016	0.013	0	57.6	58.9	36.1	161	165	0	27	28
2025	4	11	11	53	9	0.919	-0.013	3.179	0.016	0.013	0	58.5	59.3	39.6	162	166	0	26	28
2025	4	11	12	3	9	0.925	0	3.182	0.016	0.016	0	59.3	59.8	39.6	164	166	0	26	27
2025	4	11	12	13	9	0.922	-0.046	3.179	0.016	0.013	0	58.9	59.8	40.4	164	166	0	27	27
2025	4	11	12	23	9	0.955	-0.062	3.186	0.016	0.013	0	58.9	59.8	35.7	163	166	0	26	27
2025	4	11	12	33	9	0.928	-0.03	3.186	0.013	0.01	0	58.9	59.8	38.3	164	166	0	27	27
2025	4	11	12	43	9	0.896	0.016	3.179	0.016	0.013	0	58.9	59.8	38.7	163	166	0	26	27
2025	4	11	12	53	9	0.883	-0.016	3.182	0.016	0.013	0	58.9	59.8	40	164	166	0	27	27
2025	4	11	13	3	9	0.938	-0.013	3.179	0.016	0.016	0	58.9	60.2	39.6	163	166	0	26	26
2025	4	11	13	13	9	0.948	-0.026	3.182	0.016	0.013	0	58.9	59.8	40	163	165	0	26	26
2025	4	11	13	23	9	0.915	-0.036	3.182	0.013	0.01	0	58.9	59.8	38.7	163	166	0	26	27
2025	4	11	13	33	9	0.915	-0.013	3.182	0.016	0.013	0	58.9	59.8	41.3	163	166	0	26	27
2025	4	11	13	43	9	0.945	-0.026	3.186	0.016	0.016	0	58.9	59.8	39.1	163	166	0	26	27
2025	4	11	13	53	9	0.961	-0.03	3.186	0.016	0.013	0	58.5	59.3	38.7	162	165	0	26	27
2025	4	11	14	3	9	0.909	-0.039	3.186	0.016	0.016	0	58.9	59.8	38.7	163	165	0	26	26
2025	4	11	14	13	9	0.935	-0.059	3.182	0.016	0.013	0	58.5	59.3	37.8	163	165	0	27	27
2025	4	11	14	23	9	0.925	-0.049	3.182	0.016	0.013	0	58.5	59.3	39.1	162	165	0	26	27
2025	4	11	14	33	9	0.932	0.01	3.186	0.016	0.016	0	58.9	59.8	38.7	163	165	0	26	26
2025	4	11	14	43	9	0.879	-0.03	3.186	0.016	0.013	0	58.9	59.3	37.4	163	165	0	26	27
2025	4	11	14	53	9	0.909	-0.036	3.182	0.01	0.007	0	58.9	59.3	39.6	163	165	0	26	27
2025	4	11	15	3	9	0.935	-0.01	3.189	0.016	0.016	0	58.9	59.3	40.4	163	165	0	26	27
2025	4	11	15	13	9	0.935	-0.043	3.189	0.016	0.013	0	58.9	59.8	39.6	163	165	0	26	26
2025	4	11	15	23	9	0.932	-0.056	3.189	0.016	0.013	0	58.5	59.8	39.1	162	165	0	26	26
2025	4	11	15	33	9	0.915	-0.033	3.186	0.016	0.013	0	58.5	59.8	40.9	162	165	0	26	26
2025	4	11	15	43	9	0.945	-0.036	3.186	0.016	0.013	0	58.5	59.8	38.7	162	165	0	26	26
2025	4	11	15	53	9	0.915	0	3.189	0.016	0.013	0	58.9	59.8	40.4	162	165	0	25	26

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	11	16	3	9	0.938	-0.039	3.189	0.016	0.016	0	58.5	59.8	38.3	162	165	0	26	26
2025	4	11	16	13	9	0.906	-0.016	3.192	0.016	0.013	0	58.5	59.8	37	162	166	0	26	27
2025	4	11	16	23	9	0.942	0	3.182	0.016	0.013	0	58.5	60.2	39.1	162	166	0	26	26
2025	4	11	16	33	9	0.925	-0.046	3.186	0.016	0.016	0	58.5	59.8	40.4	162	166	0	26	27
2025	4	11	16	43	9	0.945	-0.046	3.186	0.013	0.01	0	58.5	60.2	41.3	162	166	0	26	26
2025	4	11	16	53	9	0.912	-0.043	3.189	0.016	0.016	0	58	59.3	37.8	161	165	0	26	27
2025	4	11	17	3	9	0.922	-0.03	3.192	0.016	0.016	0	58.5	59.8	39.6	162	165	0	26	26
2025	4	11	17	13	9	0.915	0.016	3.189	0.016	0.013	0	58	59.3	37	161	165	0	26	27
2025	4	11	17	23	9	0.932	-0.007	3.189	0.016	0.016	0	58.5	59.3	37.4	161	165	0	25	27
2025	4	11	17	33	9	0.909	-0.033	3.189	0.016	0.016	0	58	59.3	40	161	165	0	26	27
2025	4	11	17	43	9	0.935	-0.052	3.192	0.016	0.016	0	57.6	59.3	41.7	161	165	0	27	27
2025	4	11	17	53	9	0.915	-0.039	3.189	0.016	0.013	0	58	59.8	38.7	161	165	0	26	26
2025	4	11	18	3	9	0.915	-0.016	3.186	0.01	0.007	0	58	59.3	46	161	165	0	26	27
2025	4	11	18	13	9	0.919	-0.01	3.189	0.016	0.013	0	58	59.8	64.1	162	165	0	27	26
2025	4	11	18	23	9	0.899	-0.016	3.189	0.016	0.013	0	58.5	59.8	63.2	162	165	0	26	26
2025	4	11	18	33	9	0.892	0	3.189	0.016	0.013	0	58	59.8	63.2	162	165	0	27	26
2025	4	11	18	43	9	0.915	-0.023	3.189	0.016	0.016	0	58.5	59.8	63.6	162	165	0	26	26
2025	4	11	18	53	9	0.889	-0.056	3.189	0.016	0.013	0	58.5	59.3	62.8	162	165	0	26	27
2025	4	11	19	3	9	0.912	-0.003	3.189	0.01	0.007	0	58	59.8	62.8	162	165	0	27	26
2025	4	11	19	13	9	0.876	-0.033	3.189	0.016	0.013	0	58.5	59.8	62.8	162	165	0	26	26
2025	4	11	19	23	9	0.942	-0.056	3.189	0.016	0.016	0	58.5	59.8	62.8	162	165	0	26	26
2025	4	11	19	33	9	0.873	-0.043	3.189	0.016	0.016	0	58.9	59.3	62.8	162	165	0	25	27
2025	4	11	19	43	9	0.889	0.013	3.189	0.013	0.01	0	58.5	59.8	61.9	162	165	0	26	26
2025	4	11	19	53	9	0.919	-0.02	3.189	0.016	0.013	0	58.5	59.3	63.2	162	165	0	26	27
2025	4	11	20	3	9	0.932	-0.039	3.192	0.016	0.013	0	58.5	59.3	62.4	162	165	0	26	27
2025	4	11	20	13	9	0.886	0.03	3.192	0.016	0.016	0	58.5	59.8	62.4	162	166	0	26	27
2025	4	11	20	23	9	0.899	-0.036	3.192	0.016	0.013	0	58.5	59.3	62.8	162	165	0	26	27
2025	4	11	20	33	9	0.892	-0.007	3.192	0.016	0.016	0	58	59.8	62.4	162	165	0	27	26
2025	4	11	20	43	9	0.896	-0.016	3.196	0.02	0.016	0	58.5	59.8	62.8	162	165	0	26	26
2025	4	11	20	53	9	0.922	-0.01	3.196	0.016	0.013	0	58	59.3	61.1	162	165	0	27	27
2025	4	11	21	3	9	0.906	-0.026	3.199	0.013	0.01	0	58	58.9	62.8	161	164	0	26	27
2025	4	11	21	13	9	0.889	0	3.199	0.016	0.013	0	57.6	59.3	63.2	161	164	0	27	26
2025	4	11	21	23	9	0.958	-0.026	3.199	0.016	0.013	0	58	58.9	63.2	161	164	0	26	27
2025	4	11	21	33	9	0.906	-0.01	3.199	0.016	0.013	0	57.6	58.9	63.2	161	164	0	27	27
2025	4	11	21	43	9	0.892	-0.066	3.199	0.016	0.013	0	58	58.9	62.8	161	164	0	26	27
2025	4	11	21	53	9	0.915	-0.036	3.199	0.016	0.013	0	58.5	58.9	64.1	162	164	0	26	27
2025	4	11	22	3	9	0.906	0	3.199	0.013	0.01	0	58.5	59.8	63.6	162	165	0	26	26
2025	4	11	22	13	9	0.935	-0.03	3.199	0.013	0.01	0	58	58.9	64.1	161	164	0	26	27
2025	4	11	22	23	9	0.909	0	3.199	0.013	0.01	0	58.5	59.8	63.6	162	165	0	26	26
2025	4	11	22	33	9	0.945	-0.013	3.199	0.016	0.016	0	58.5	59.3	63.6	162	165	0	26	27
2025	4	11	22	43	9	0.925	-0.01	3.199	0.016	0.013	0	58.5	59.3	63.6	162	165	0	26	27
2025	4	11	22	53	9	0.945	-0.043	3.199	0.013	0.01	0	58	58.9	64.5	161	164	0	26	27
2025	4	11	23	3	9	0.932	-0.046	3.199	0.016	0.013	0	58	58.9	64.5	161	164	0	26	27
2025	4	11	23	13	9	0.932	-0.003	3.199	0.016	0.013	0	58	58.9	64.5	162	165	0	27	28
2025	4	11	23	23	9	0.869	-0.003	3.199	0.013	0.01	0	58.5	59.3	64.1	162	165	0	26	27
2025	4	11	23	33	9	0.915	-0.03	3.199	0.016	0.013	0	58.5	59.3	64.9	162	165	0	26	27
2025	4	11	23	43	9	0.928	-0.033	3.199	0.013	0.01	0	58	59.8	64.9	162	165	0	27	26
2025	4	11	23	53	9	0.889	-0.046	3.199	0.016	0.013	0	58	59.3	64.9	162	165	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	12	0	3	9	0.906	-0.049	3.199	0.016	0.013	0	58	59.3	65.8	162	165	0	27	27
2025	4	12	0	13	9	0.896	-0.056	3.199	0.016	0.013	0	58.5	59.3	64.9	162	165	0	26	27
2025	4	12	0	23	9	0.909	0.026	3.199	0.016	0.016	0	58.5	59.3	65.4	162	165	0	26	27
2025	4	12	0	33	9	0.899	-0.046	3.199	0.016	0.013	0	58.5	59.3	65.4	162	165	0	26	27
2025	4	12	0	43	9	0.948	-0.056	3.199	0.016	0.013	0	57.6	59.3	66.2	161	165	0	27	27
2025	4	12	0	53	9	0.925	-0.02	3.199	0.013	0.01	0	58.9	59.3	65.8	162	165	0	25	27
2025	4	12	1	3	9	0.912	-0.023	3.199	0.016	0.013	0	58	59.3	65.4	162	165	0	27	27
2025	4	12	1	13	9	0.915	-0.039	3.199	0.02	0.016	0	58.5	59.3	65.8	162	165	0	26	27
2025	4	12	1	23	9	0.896	0	3.199	0.02	0.016	0	58.5	59.8	66.2	162	165	0	26	26
2025	4	12	1	33	9	0.906	-0.023	3.199	0.016	0.013	0	58.5	59.3	65.8	162	165	0	26	27
2025	4	12	1	43	9	0.906	-0.059	3.199	0.016	0.013	0	58.5	58.9	65.8	162	165	0	26	28
2025	4	12	1	53	9	0.951	-0.043	3.199	0.013	0.01	0	58.5	59.3	65.4	162	165	0	26	27
2025	4	12	2	3	9	0.928	-0.052	3.199	0.016	0.013	0	57.6	59.3	65.8	161	165	0	27	27
2025	4	12	2	13	9	0.932	-0.03	3.199	0.016	0.013	0	56.8	59.3	65.8	158	165	0	26	27
2025	4	12	2	23	9	0.906	0	3.199	0.02	0.016	0	57.2	59.3	64.5	160	165	0	27	27
2025	4	12	2	33	9	0.909	-0.056	3.196	0.016	0.013	0	58.9	59.8	65.8	163	166	0	26	27
2025	4	12	2	43	9	0.886	-0.016	3.196	0.016	0.013	0	58	59.3	65.8	162	165	0	27	27
2025	4	12	2	53	9	0.935	-0.062	3.199	0.016	0.016	0	58.5	59.3	65.8	162	165	0	26	27
2025	4	12	3	3	9	0.938	-0.079	3.196	0.013	0.01	0	58	59.3	65.8	162	165	0	27	27
2025	4	12	3	13	9	0.912	-0.01	3.196	0.016	0.016	0	58	59.3	65.8	162	165	0	27	27
2025	4	12	3	23	9	0.912	-0.026	3.196	0.016	0.013	0	58.5	59.8	65.4	162	166	0	26	27
2025	4	12	3	33	9	0.889	-0.03	3.196	0.016	0.013	0	58	59.3	62.8	162	165	0	27	27
2025	4	12	3	43	9	0.912	-0.046	3.196	0.016	0.013	0	58	59.8	64.5	162	165	0	27	26
2025	4	12	3	53	9	0.886	-0.03	3.196	0.016	0.013	0	58.9	59.8	64.9	163	166	0	26	27
2025	4	12	4	3	9	0.899	-0.016	3.196	0.016	0.013	0	58	58.9	65.8	162	165	0	27	28
2025	4	12	4	13	9	0.935	-0.023	3.196	0.016	0.013	0	58	58.9	65.4	162	165	0	27	28
2025	4	12	4	23	9	0.899	-0.026	3.196	0.016	0.013	0	58.5	59.8	64.5	162	166	0	26	27
2025	4	12	4	33	9	0.912	-0.043	3.196	0.013	0.01	0	58.5	58.9	65.8	162	165	0	26	28
2025	4	12	4	43	9	0.899	-0.059	3.196	0.016	0.013	0	58.5	58.9	64.5	162	165	0	26	28
2025	4	12	4	53	9	0.955	-0.026	3.196	0.016	0.013	0	58	58.9	64.5	162	165	0	27	28
2025	4	12	5	3	9	0.948	-0.046	3.196	0.016	0.013	0	58.5	58.9	61.5	162	165	0	26	28
2025	4	12	5	13	9	0.951	-0.039	3.196	0.013	0.01	0	58	59.8	65.8	162	166	0	27	27
2025	4	12	5	23	9	0.938	-0.003	3.196	0.013	0.01	0	58.5	60.2	64.9	163	167	0	27	27
2025	4	12	5	33	9	0.909	-0.056	3.196	0.013	0.01	0	58.9	59.8	65.4	163	166	0	26	27
2025	4	12	5	43	9	0.925	-0.036	3.196	0.016	0.013	0	58.5	59.8	64.5	163	166	0	27	27
2025	4	12	5	53	9	0.899	-0.026	3.196	0.016	0.013	0	58.5	59.8	64.5	163	166	0	27	27
2025	4	12	6	3	9	0.912	-0.016	3.196	0.016	0.013	0	58	59.8	64.9	163	166	0	28	27
2025	4	12	6	13	9	0.909	-0.026	3.192	0.016	0.016	0	58.5	59.8	64.9	163	166	0	27	27
2025	4	12	6	23	9	0.909	0.01	3.196	0.013	0.01	0	58.5	60.2	64.5	163	167	0	27	27
2025	4	12	6	33	9	0.922	-0.03	3.196	0.013	0.01	0	58.5	59.8	64.9	163	166	0	27	27
2025	4	12	6	43	9	0.928	-0.039	3.196	0.016	0.013	0	58.5	59.8	64.9	163	167	0	27	28
2025	4	12	6	53	9	0.928	-0.033	3.196	0.016	0.013	0	58.9	59.8	64.1	164	167	0	27	28
2025	4	12	7	3	9	0.922	0.01	3.192	0.016	0.016	0	58.9	59.8	64.1	164	167	0	27	28
2025	4	12	7	13	9	0.922	-0.033	3.196	0.013	0.01	0	58.9	60.2	64.9	164	167	0	27	27
2025	4	12	7	23	9	0.909	-0.02	3.196	0.016	0.013	0	58.5	60.2	64.9	163	167	0	27	27
2025	4	12	7	33	9	0.912	-0.033	3.196	0.01	0.007	0	58.5	60.2	64.9	163	167	0	27	27
2025	4	12	7	43	9	0.925	-0.02	3.196	0.016	0.016	0	58.5	60.2	64.5	163	167	0	27	27
2025	4	12	7	53	9	0.912	-0.033	3.196	0.016	0.013	0	58.5	59.3	64.9	163	166	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	12	8	3	9	0.945	-0.066	3.196	0.016	0.013	0	58.9	59.8	64.5	163	166	0	26	27
2025	4	12	8	13	9	0.955	-0.023	3.196	0.016	0.016	0	58.5	60.2	64.5	163	167	0	27	27
2025	4	12	8	23	9	0.912	-0.033	3.196	0.016	0.016	0	58.9	59.8	64.9	164	167	0	27	28
2025	4	12	8	33	9	0.938	-0.046	3.196	0.016	0.013	0	58.9	60.2	64.1	164	167	0	27	27
2025	4	12	8	43	9	0.942	-0.043	3.196	0.013	0.01	0	58.9	59.8	65.4	163	167	0	26	28
2025	4	12	8	53	9	0.925	-0.007	3.196	0.01	0.007	0	58.5	59.8	64.9	163	166	0	27	27
2025	4	12	9	3	9	0.912	-0.023	3.196	0.016	0.016	0	58.9	59.8	64.9	163	167	0	26	28
2025	4	12	9	13	9	0.945	-0.033	3.196	0.013	0.01	0	58.5	60.2	64.9	163	167	0	27	27
2025	4	12	9	23	9	0.925	-0.033	3.196	0.016	0.016	0	58.5	60.6	64.1	163	167	0	27	26
2025	4	12	9	33	9	0.932	-0.043	3.196	0.016	0.013	0	58.5	60.2	46.4	163	167	0	27	27
2025	4	12	9	43	9	0.945	-0.043	3.196	0.016	0.013	0	58.5	59.8	48.2	163	166	0	27	27
2025	4	12	9	53	9	0.945	-0.036	3.196	0.016	0.013	0	58.9	59.8	51.2	163	166	0	26	27
2025	4	12	10	3	9	0.948	-0.062	3.196	0.013	0.01	0	58	59.8	45.2	162	166	0	27	27
2025	4	12	10	13	9	0.948	-0.052	3.196	0.016	0.013	0	58.9	59.8	44.3	163	166	0	26	27
2025	4	12	10	23	9	0.909	-0.023	3.199	0.016	0.013	0	58.9	59.8	56.8	163	166	0	26	27
2025	4	12	10	33	9	0.915	-0.033	3.199	0.016	0.013	0	58.9	59.8	40.4	163	166	0	26	27
2025	4	12	10	43	9	0.922	-0.046	3.199	0.016	0.013	0	58.5	60.2	37.8	163	167	0	27	27
2025	4	12	10	53	9	0.922	-0.046	3.199	0.013	0.01	0	58.5	59.8	41.3	163	166	0	27	27
2025	4	12	11	3	9	0.902	-0.02	3.199	0.02	0.016	0	58.5	60.2	43.9	163	167	0	27	27
2025	4	12	11	13	9	0.928	-0.01	3.202	0.013	0.01	0	58.5	59.8	43.4	163	166	0	27	27
2025	4	12	11	23	9	0.902	-0.03	3.202	0.016	0.013	0	58.5	59.8	39.1	163	166	0	27	27
2025	4	12	11	33	9	0.955	-0.03	3.199	0.016	0.013	0	58.5	60.2	44.3	163	166	0	27	26
2025	4	12	11	43	9	0.948	-0.023	3.199	0.013	0.01	0	58.9	60.2	42.6	163	166	0	26	26
2025	4	12	11	53	9	0.912	-0.016	3.196	0.016	0.013	0	59.3	60.2	37.4	164	167	0	26	27
2025	4	12	12	3	9	0.902	-0.007	3.202	0.016	0.016	0	58.5	59.8	42.6	163	166	0	27	27
2025	4	12	12	13	9	0.906	-0.059	3.202	0.013	0.01	0	58	59.8	43	162	166	0	27	27
2025	4	12	12	23	9	0.971	-0.03	3.202	0.02	0.016	0	58.5	59.8	58.5	163	166	0	27	27
2025	4	12	12	33	9	0.902	-0.046	3.202	0.016	0.013	0	59.3	59.8	55	163	166	0	25	27
2025	4	12	12	43	9	0.909	-0.046	3.202	0.016	0.016	0	58	59.8	41.7	162	166	0	27	27
2025	4	12	12	53	9	0.902	-0.016	3.202	0.016	0.013	0	58.5	60.2	51.6	163	166	0	27	26
2025	4	12	13	3	9	0.958	-0.043	3.205	0.016	0.013	0	58.9	60.2	64.9	163	166	0	26	26
2025	4	12	13	13	9	0.892	-0.056	3.202	0.016	0.016	0	58.9	59.8	41.7	163	166	0	26	27
2025	4	12	13	23	9	0.932	-0.02	3.205	0.016	0.013	0	58.9	60.2	64.5	163	167	0	26	27
2025	4	12	13	33	9	0.896	-0.046	3.202	0.016	0.013	0	59.8	61.5	43	166	170	0	27	27
2025	4	12	13	43	9	0.925	-0.016	3.209	0.013	0.01	0	58.5	60.2	60.6	163	167	0	27	27
2025	4	12	13	53	9	0.932	-0.026	3.205	0.016	0.013	0	58.9	60.2	43.4	163	166	0	26	26
2025	4	12	14	3	9	0.971	-0.03	3.205	0.016	0.013	0	58.9	59.8	49.5	163	166	0	26	27
2025	4	12	14	13	9	0.955	-0.052	3.202	0.016	0.013	0	58.9	60.2	43	163	166	0	26	26
2025	4	12	14	23	9	0.938	-0.046	3.202	0.013	0.01	0	58.5	60.2	45.2	162	166	0	26	26
2025	4	12	14	33	9	0.932	-0.03	3.205	0.016	0.013	0	58.5	60.2	52.9	162	166	0	26	26
2025	4	12	14	43	9	0.915	-0.023	3.205	0.016	0.016	0	58.9	59.8	47.3	163	166	0	26	27
2025	4	12	14	53	9	0.951	-0.016	3.205	0.016	0.013	0	58.5	60.2	51.2	162	166	0	26	26
2025	4	12	15	3	9	0.938	-0.033	3.209	0.013	0.01	0	58.9	59.8	44.7	163	166	0	26	27
2025	4	12	15	13	9	0.958	-0.033	3.209	0.016	0.013	0	58.5	59.8	53.3	162	166	0	26	27
2025	4	12	15	23	9	0.932	-0.049	3.209	0.016	0.013	0	58.5	59.8	55	162	166	0	26	27
2025	4	12	15	33	9	0.938	-0.02	3.209	0.013	0.01	0	58.5	59.8	49.9	162	166	0	26	27
2025	4	12	15	43	9	0.932	0	3.209	0.016	0.013	0	58	60.2	51.2	162	166	0	27	26
2025	4	12	15	53	9	0.912	-0.033	3.209	0.016	0.016	0	58.5	60.6	46	162	167	0	26	26

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	12	16	3	9	0.909	-0.016	3.209	0.016	0.013	0	58.5	60.2	52.9	163	166	0	27	26
2025	4	12	16	13	9	0.928	-0.026	3.209	0.013	0.01	0	58.5	60.2	46.4	162	166	0	26	26
2025	4	12	16	23	9	0.932	0	3.209	0.016	0.013	0	58	60.6	44.3	162	167	0	27	26
2025	4	12	16	33	9	0.925	-0.01	3.209	0.016	0.016	0	58.5	60.6	45.2	162	167	0	26	26
2025	4	12	16	43	9	0.909	-0.007	3.209	0.016	0.013	0	58.9	60.2	48.2	163	167	0	26	27
2025	4	12	16	53	9	0.919	-0.02	3.209	0.016	0.013	0	58.9	60.6	43.9	163	167	0	26	26
2025	4	12	17	3	9	0.892	0.013	3.209	0.016	0.013	0	58.5	59.8	46.9	162	166	0	26	27
2025	4	12	17	13	9	0.919	-0.043	3.209	0.013	0.01	0	58.5	60.2	45.6	162	166	0	26	26
2025	4	12	17	23	9	0.896	-0.016	3.209	0.013	0.01	0	58	59.3	44.3	161	165	0	26	27
2025	4	12	17	33	9	0.915	-0.039	3.209	0.013	0.01	0	58.5	59.8	47.3	162	165	0	26	26
2025	4	12	17	43	9	0.922	-0.02	3.209	0.016	0.013	0	58	59.3	46.9	161	165	0	26	27
2025	4	12	17	53	9	0.915	-0.013	3.209	0.013	0.01	0	58.5	59.3	46	162	165	0	26	27
2025	4	12	18	3	9	0.938	0.003	3.209	0.016	0.016	0	58.5	59.8	54.6	162	166	0	26	27
2025	4	12	18	13	9	0.935	0.01	3.212	0.016	0.013	0	58	59.8	58	162	165	0	27	26
2025	4	12	18	23	9	0.935	0.007	3.212	0.016	0.013	0	58.5	59.8	64.1	162	166	0	26	27
2025	4	12	18	33	9	0.899	-0.007	3.212	0.016	0.016	0	58	59.8	60.6	162	165	0	27	26
2025	4	12	18	43	9	0.932	-0.023	3.212	0.016	0.016	0	57.6	59.3	63.2	161	165	0	27	27
2025	4	12	18	53	9	0.922	-0.043	3.212	0.016	0.013	0	58	59.3	60.2	162	165	0	27	27
2025	4	12	19	3	9	0.945	-0.01	3.212	0.013	0.01	0	57.6	60.2	65.4	160	166	0	26	26
2025	4	12	19	13	9	0.932	-0.003	3.212	0.016	0.016	0	58.5	59.3	65.4	162	165	0	26	27
2025	4	12	19	23	9	0.932	-0.02	3.212	0.013	0.01	0	58.5	59.8	66.2	162	166	0	26	27
2025	4	12	19	33	9	0.925	-0.016	3.212	0.01	0.007	0	58.5	59.3	65.8	162	165	0	26	27
2025	4	12	19	43	9	0.932	-0.02	3.212	0.016	0.016	0	58.5	59.3	65.8	162	165	0	26	27
2025	4	12	19	53	9	0.955	0	3.212	0.016	0.013	0	58.5	59.8	65.8	162	165	0	26	26
2025	4	12	20	3	9	0.928	-0.03	3.212	0.016	0.013	0	58.5	59.3	65.4	162	165	0	26	27
2025	4	12	20	13	9	0.955	-0.043	3.212	0.01	0.007	0	58	59.8	66.2	161	165	0	26	26
2025	4	12	20	23	9	0.899	-0.03	3.212	0.016	0.013	0	58.5	59.3	64.9	162	165	0	26	27
2025	4	12	20	33	9	0.922	-0.036	3.212	0.016	0.016	0	58.5	59.3	61.9	162	165	0	26	27
2025	4	12	20	43	9	0.925	-0.03	3.212	0.016	0.016	0	58	59.3	65.8	161	164	0	26	26
2025	4	12	20	53	9	0.958	-0.03	3.212	0.016	0.016	0	58.5	59.3	57.6	162	165	0	26	27
2025	4	12	21	3	9	0.938	-0.013	3.212	0.016	0.013	0	58	59.3	64.9	161	165	0	26	27
2025	4	12	21	13	9	0.938	-0.03	3.212	0.013	0.01	0	57.6	59.8	63.6	161	165	0	27	26
2025	4	12	21	23	9	0.945	-0.03	3.212	0.016	0.013	0	58	59.3	64.5	161	165	0	26	27
2025	4	12	21	33	9	0.912	0	3.212	0.016	0.013	0	58.5	59.8	47.7	162	165	0	26	26
2025	4	12	21	43	9	0.945	-0.056	3.212	0.016	0.013	0	58	59.3	43	161	165	0	26	27
2025	4	12	21	53	9	0.938	-0.013	3.209	0.016	0.013	0	58.5	59.8	55	161	165	0	25	26
2025	4	12	22	3	9	0.948	-0.026	3.209	0.016	0.013	0	58	59.8	60.6	161	165	0	26	26
2025	4	12	22	13	9	0.928	-0.033	3.209	0.016	0.013	0	58.5	59.3	50.3	162	165	0	26	27
2025	4	12	22	23	9	0.942	-0.059	3.212	0.016	0.013	0	58	59.3	46.4	161	165	0	26	27
2025	4	12	22	33	9	0.935	-0.013	3.209	0.013	0.01	0	58	59.3	46	162	165	0	27	27
2025	4	12	22	43	9	0.928	-0.026	3.209	0.013	0.01	0	58	59.3	60.2	162	165	0	27	27
2025	4	12	22	53	9	0.942	-0.003	3.209	0.013	0.01	0	58	59.8	59.3	162	166	0	27	27
2025	4	12	23	3	9	0.928	-0.036	3.209	0.01	0.007	0	58.5	59.3	60.6	162	165	0	26	27
2025	4	12	23	13	9	0.932	-0.007	3.209	0.016	0.013	0	57.6	59.3	58	161	165	0	27	27
2025	4	12	23	23	9	0.928	-0.075	3.209	0.016	0.013	0	57.6	59.3	54.6	161	165	0	27	27
2025	4	12	23	33	9	0.915	-0.016	3.209	0.016	0.016	0	57.6	59.3	55	161	165	0	27	27
2025	4	12	23	43	9	0.932	-0.046	3.209	0.016	0.013	0	57.6	59.3	62.4	161	165	0	27	27
2025	4	12	23	53	9	0.922	-0.033	3.209	0.013	0.01	0	58	59.3	51.6	162	165	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	13	0	3	9	0.942	-0.026	3.209	0.01	0.007	0	58	59.3	53.8	162	165	0	27	27
2025	4	13	0	13	9	0.919	-0.003	3.209	0.016	0.013	0	58.5	59.8	46.4	162	166	0	26	27
2025	4	13	0	23	9	0.925	-0.016	3.209	0.013	0.01	0	58	59.8	43	162	166	0	27	27
2025	4	13	0	33	9	0.945	-0.036	3.209	0.016	0.016	0	58	59.3	43.4	162	165	0	27	27
2025	4	13	0	43	9	0.925	-0.075	3.209	0.016	0.013	0	58	59.3	42.1	162	165	0	27	27
2025	4	13	0	53	9	0.971	-0.036	3.212	0.016	0.016	0	58.5	59.3	41.3	162	165	0	26	27
2025	4	13	1	3	9	0.971	-0.036	3.212	0.016	0.016	0	58.5	59.3	40.4	162	165	0	26	27
2025	4	13	1	13	9	0.942	-0.016	3.209	0.016	0.013	0	58.5	59.3	40.9	162	165	0	26	27
2025	4	13	1	23	9	0.892	-0.013	3.212	0.016	0.013	0	58.9	59.8	40	163	166	0	26	27
2025	4	13	1	33	9	0.932	-0.03	3.212	0.016	0.013	0	58.5	59.8	41.7	163	166	0	27	27
2025	4	13	1	43	9	0.919	-0.016	3.212	0.013	0.01	0	58.9	59.8	40.4	163	166	0	26	27
2025	4	13	1	53	9	0.932	-0.069	3.212	0.016	0.013	0	58	59.3	41.3	162	165	0	27	27
2025	4	13	2	3	9	0.984	-0.023	3.212	0.016	0.013	0	58	59.8	40.9	162	166	0	27	27
2025	4	13	2	13	9	0.919	-0.03	3.215	0.016	0.016	0	58.5	59.3	39.6	162	166	0	26	28
2025	4	13	2	23	9	0.938	-0.036	3.212	0.016	0.013	0	58	59.8	39.1	162	166	0	27	27
2025	4	13	2	33	9	0.955	-0.052	3.215	0.013	0.01	0	58	59.8	40.9	162	166	0	27	27
2025	4	13	2	43	9	0.925	-0.046	3.212	0.013	0.01	0	58	59.3	42.6	162	166	0	27	28
2025	4	13	2	53	9	0.919	-0.056	3.212	0.016	0.016	0	58.5	59.8	40	163	166	0	27	27
2025	4	13	3	3	9	0.932	-0.043	3.212	0.016	0.013	0	58.5	59.3	40	162	166	0	26	28
2025	4	13	3	13	9	0.955	-0.03	3.212	0.016	0.016	0	58	59.3	40	162	166	0	27	28
2025	4	13	3	23	9	0.928	-0.013	3.215	0.016	0.013	0	58.5	59.8	40	163	166	0	27	27
2025	4	13	3	33	9	0.945	-0.033	3.215	0.016	0.016	0	58	59.3	40	162	166	0	27	28
2025	4	13	3	43	9	0.942	-0.079	3.215	0.016	0.016	0	58	59.8	40	162	166	0	27	27
2025	4	13	3	53	9	0.922	-0.03	3.215	0.013	0.01	0	58.5	59.8	38.7	163	166	0	27	27
2025	4	13	4	3	9	0.951	-0.036	3.212	0.013	0.01	0	58	59.8	40	162	166	0	27	27
2025	4	13	4	13	9	0.945	-0.033	3.215	0.013	0.01	0	58	59.8	39.1	162	166	0	27	27
2025	4	13	4	23	9	0.919	-0.049	3.215	0.013	0.01	0	58	59.8	39.6	162	166	0	27	27
2025	4	13	4	33	9	0.951	-0.069	3.212	0.013	0.01	0	58	59.8	38.7	162	166	0	27	27
2025	4	13	4	43	9	0.932	-0.049	3.215	0.013	0.01	0	58.5	59.8	40.4	163	166	0	27	27
2025	4	13	4	53	9	0.935	-0.023	3.215	0.016	0.013	0	58.5	59.3	40.9	163	166	0	27	28
2025	4	13	5	3	9	0.928	-0.039	3.212	0.013	0.01	0	58.5	59.8	40	163	166	0	27	27
2025	4	13	5	13	9	0.935	-0.013	3.215	0.016	0.013	0	58.5	59.8	40.9	163	166	0	27	27
2025	4	13	5	23	9	0.928	-0.049	3.215	0.013	0.01	0	58.5	59.8	40.4	163	166	0	27	27
2025	4	13	5	33	9	0.912	-0.023	3.215	0.016	0.013	0	58.5	59.8	40	163	166	0	27	27
2025	4	13	5	43	9	0.932	-0.056	3.215	0.016	0.013	0	58.5	59.3	40.9	163	166	0	27	28
2025	4	13	5	53	9	0.899	-0.01	3.215	0.016	0.013	0	58.9	59.8	40	163	166	0	26	27
2025	4	13	6	3	9	0.961	-0.036	3.215	0.016	0.013	0	58	59.3	39.6	162	166	0	27	28
2025	4	13	6	13	9	0.942	-0.049	3.215	0.016	0.013	0	58.5	59.8	39.6	163	166	0	27	27
2025	4	13	6	23	9	0.932	-0.072	3.215	0.013	0.01	0	58	59.8	39.1	163	167	0	28	28
2025	4	13	6	33	9	0.912	-0.052	3.215	0.016	0.016	0	58.9	60.2	37.8	164	167	0	27	27
2025	4	13	6	43	9	0.928	-0.02	3.212	0.016	0.013	0	58.9	60.2	37.8	164	167	0	27	27
2025	4	13	6	53	9	0.938	-0.046	3.212	0.016	0.013	0	58.9	59.8	38.3	164	167	0	27	28
2025	4	13	7	3	9	0.958	-0.033	3.212	0.013	0.01	0	58.9	59.8	37.4	164	167	0	27	28
2025	4	13	7	13	9	0.968	-0.023	3.209	0.02	0.016	0	58.9	59.8	39.6	164	167	0	27	28
2025	4	13	7	23	9	0.951	-0.062	3.212	0.016	0.013	0	58.5	59.8	38.7	163	167	0	27	28
2025	4	13	7	33	9	0.942	-0.023	3.212	0.016	0.016	0	58.9	60.2	38.7	164	167	0	27	27
2025	4	13	7	43	9	0.925	0	3.212	0.01	0.007	0	58.9	60.6	37	164	168	0	27	27
2025	4	13	7	53	9	0.971	-0.036	3.212	0.013	0.01	0	58.9	60.2	40	164	167	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	13	8	3	9	0.915	-0.039	3.209	0.016	0.013	0	58.9	60.2	39.6	164	167	0	27	27
2025	4	13	8	13	9	0.935	-0.02	3.212	0.016	0.013	0	58.9	59.8	40.4	164	167	0	27	28
2025	4	13	8	23	9	0.912	-0.007	3.212	0.013	0.01	0	58.9	59.8	39.6	164	167	0	27	28
2025	4	13	8	33	9	0.945	-0.059	3.209	0.016	0.016	0	58.9	59.8	39.1	164	167	0	27	28
2025	4	13	8	43	9	0.925	-0.052	3.212	0.01	0.007	0	58.9	59.8	39.6	164	167	0	27	28
2025	4	13	8	53	9	0.925	-0.03	3.212	0.01	0.007	0	58.9	59.8	39.1	164	167	0	27	28
2025	4	13	9	3	9	0.912	-0.043	3.209	0.016	0.016	0	59.3	59.8	39.6	164	167	0	26	28
2025	4	13	9	13	9	0.938	-0.043	3.212	0.013	0.01	0	58.9	59.8	39.6	164	167	0	27	28
2025	4	13	9	23	9	0.906	-0.03	3.212	0.016	0.013	0	58.9	60.2	38.3	164	168	0	27	28
2025	4	13	9	33	9	0.942	-0.033	3.212	0.016	0.013	0	58.9	60.2	40.9	164	167	0	27	27
2025	4	13	9	43	9	0.919	-0.069	3.212	0.013	0.01	0	58.9	60.2	40.4	164	167	0	27	27
2025	4	13	9	53	9	0.945	-0.007	3.212	0.016	0.013	0	58.9	60.2	40.4	164	167	0	27	27
2025	4	13	10	3	9	0.945	-0.059	3.212	0.016	0.013	0	58	59.8	40.9	163	166	0	28	27
2025	4	13	10	13	9	0.896	-0.016	3.212	0.013	0.01	0	58.9	59.8	41.3	163	167	0	26	28
2025	4	13	10	23	9	0.932	-0.013	3.212	0.016	0.013	0	58.9	59.8	39.1	164	167	0	27	28
2025	4	13	10	33	9	0.935	-0.023	3.212	0.016	0.013	0	58.5	59.8	39.6	163	167	0	27	28
2025	4	13	10	43	9	0.919	-0.046	3.209	0.016	0.013	0	58.5	60.2	40	163	167	0	27	27
2025	4	13	10	53	9	0.928	-0.033	3.212	0.016	0.013	0	58	59.8	39.1	163	166	0	28	27
2025	4	13	11	3	9	0.909	-0.01	3.212	0.016	0.016	0	58.5	59.8	40.4	163	166	0	27	27
2025	4	13	11	13	9	0.942	-0.052	3.209	0.013	0.01	0	58.5	59.8	39.1	163	166	0	27	27
2025	4	13	11	23	9	0.906	-0.03	3.212	0.016	0.013	0	58.9	59.8	40	163	166	0	26	27
2025	4	13	11	33	9	0.955	-0.043	3.209	0.013	0.01	0	58.5	59.3	43.9	163	166	0	27	28
2025	4	13	11	43	9	0.906	-0.026	3.209	0.016	0.013	0	58.5	60.2	55.5	163	167	0	27	27
2025	4	13	11	53	9	0.919	0.007	3.209	0.016	0.016	0	59.3	60.2	48.6	164	167	0	26	27
2025	4	13	12	3	9	0.906	-0.003	3.209	0.016	0.016	0	58.5	59.3	50.7	163	166	0	27	28
2025	4	13	12	13	9	0.915	-0.016	3.205	0.016	0.013	0	58.9	59.3	55.5	163	166	0	26	28
2025	4	13	12	23	9	0.919	-0.043	3.209	0.016	0.016	0	58.5	59.8	58	163	166	0	27	27
2025	4	13	12	33	9	0.942	-0.039	3.205	0.016	0.013	0	58.5	59.8	50.3	163	166	0	27	27
2025	4	13	12	43	9	0.912	-0.01	3.209	0.016	0.016	0	58.5	59.8	62.4	163	166	0	27	27
2025	4	13	12	53	9	0.928	-0.043	3.209	0.016	0.013	0	58.9	59.3	63.6	163	166	0	26	28
2025	4	13	13	3	9	0.919	-0.03	3.209	0.016	0.013	0	58.5	59.8	64.1	163	166	0	27	27
2025	4	13	13	13	9	0.938	-0.023	3.209	0.013	0.01	0	58.5	59.8	61.5	163	166	0	27	27
2025	4	13	13	23	9	0.942	0.003	3.209	0.013	0.01	0	58.5	59.8	50.7	163	166	0	27	27
2025	4	13	13	33	9	0.928	-0.049	3.209	0.013	0.01	0	58.5	59.8	63.6	162	166	0	26	27
2025	4	13	13	43	9	0.932	-0.046	3.209	0.016	0.013	0	58.5	59.8	59.3	163	166	0	27	27
2025	4	13	13	53	9	0.938	-0.03	3.209	0.016	0.013	0	58	59.8	64.5	162	166	0	27	27
2025	4	13	14	3	9	0.922	-0.016	3.209	0.01	0.007	0	58.5	60.2	63.2	163	166	0	27	26
2025	4	13	14	13	9	0.935	-0.043	3.209	0.013	0.01	0	58	59.8	61.1	162	166	0	27	27
2025	4	13	14	23	9	0.932	-0.033	3.209	0.016	0.013	0	58	59.8	64.1	162	166	0	27	27
2025	4	13	14	33	9	0.932	-0.003	3.209	0.016	0.013	0	58.5	59.8	48.6	163	166	0	27	27
2025	4	13	14	43	9	0.955	0	3.212	0.01	0.007	0	58.5	59.8	63.6	162	166	0	26	27
2025	4	13	14	53	9	0.945	-0.039	3.212	0.016	0.013	0	58	59.8	64.1	162	166	0	27	27
2025	4	13	15	3	9	0.938	-0.033	3.212	0.013	0.01	0	58.5	59.3	65.4	162	165	0	26	27
2025	4	13	15	13	9	0.909	-0.043	3.212	0.013	0.01	0	58.5	59.3	63.6	162	165	0	26	27
2025	4	13	15	23	9	0.948	-0.059	3.212	0.016	0.013	0	58.5	59.3	66.2	162	165	0	26	27
2025	4	13	15	33	9	0.912	-0.03	3.212	0.016	0.013	0	58.5	59.3	63.6	162	165	0	26	27
2025	4	13	15	43	9	0.912	0	3.212	0.016	0.013	0	58.5	59.3	64.1	162	165	0	26	27
2025	4	13	15	53	9	0.938	-0.036	3.212	0.016	0.013	0	58.5	59.3	64.9	162	165	0	26	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	13	16	3	9	0.955	-0.043	3.212	0.013	0.01	0	57.6	59.8	45.2	161	165	0	27	26
2025	4	13	16	13	9	0.919	-0.013	3.212	0.016	0.013	0	58	59.3	63.2	162	165	0	27	27
2025	4	13	16	23	9	0.958	-0.03	3.212	0.016	0.016	0	58	59.3	58.9	161	165	0	26	27
2025	4	13	16	33	9	0.942	-0.003	3.212	0.013	0.01	0	58.5	59.8	65.8	162	165	0	26	26
2025	4	13	16	43	9	0.942	-0.01	3.212	0.013	0.01	0	58.5	59.3	66.2	162	165	0	26	27
2025	4	13	16	53	9	0.928	-0.03	3.212	0.01	0.007	0	57.6	59.3	66.2	161	165	0	27	27
2025	4	13	17	3	9	0.925	0.01	3.212	0.013	0.01	0	58	59.3	65.4	161	165	0	26	27
2025	4	13	17	13	9	0.942	-0.043	3.212	0.013	0.01	0	58	58.9	65.8	161	164	0	26	27
2025	4	13	17	23	9	0.965	-0.059	3.212	0.016	0.016	0	57.6	58.9	65.8	161	164	0	27	27
2025	4	13	17	33	9	0.919	-0.03	3.212	0.016	0.016	0	57.6	58.9	64.9	161	164	0	27	27
2025	4	13	17	43	9	0.945	-0.007	3.212	0.02	0.016	0	57.6	58.5	64.9	161	164	0	27	28
2025	4	13	17	53	9	0.935	-0.013	3.212	0.016	0.013	0	58	58.9	63.6	161	164	0	26	27
2025	4	13	18	3	9	0.981	-0.02	3.212	0.02	0.016	0	57.6	58.9	64.9	161	164	0	27	27
2025	4	13	18	13	9	0.938	-0.043	3.212	0.016	0.013	0	57.6	58.5	65.4	160	163	0	26	27
2025	4	13	18	23	9	0.951	-0.033	3.212	0.016	0.013	0	57.6	59.3	64.9	160	164	0	26	26
2025	4	13	18	33	9	0.912	-0.046	3.212	0.016	0.013	0	58	59.3	65.8	161	164	0	26	26
2025	4	13	18	43	9	0.948	-0.026	3.212	0.016	0.016	0	57.6	58.9	66.2	160	164	0	26	27
2025	4	13	18	53	9	0.948	-0.059	3.209	0.016	0.013	0	57.6	58.9	65.8	160	164	0	26	27
2025	4	13	19	3	9	0.932	-0.013	3.209	0.016	0.013	0	58	58.9	65.8	161	164	0	26	27
2025	4	13	19	13	9	0.935	-0.026	3.209	0.016	0.016	0	57.6	59.3	65.4	160	164	0	26	26
2025	4	13	19	23	9	0.945	-0.03	3.209	0.016	0.013	0	57.2	59.3	66.2	160	164	0	27	26
2025	4	13	19	33	9	0.919	-0.049	3.209	0.013	0.01	0	57.6	58.9	65.8	160	164	0	26	27
2025	4	13	19	43	9	0.919	-0.016	3.209	0.01	0.007	0	58	58.9	65.4	161	164	0	26	27
2025	4	13	19	53	9	0.948	-0.043	3.209	0.016	0.013	0	57.6	58.9	66.2	160	164	0	26	27
2025	4	13	20	3	9	0.932	-0.046	3.209	0.013	0.01	0	57.2	58.9	66.2	160	164	0	27	27
2025	4	13	20	13	9	0.942	-0.003	3.209	0.016	0.016	0	57.6	58.9	66.2	160	164	0	26	27
2025	4	13	20	23	9	0.928	-0.033	3.209	0.016	0.013	0	57.2	58.9	66.2	160	164	0	27	27
2025	4	13	20	33	9	0.932	-0.046	3.205	0.016	0.016	0	57.6	58.5	65.8	160	163	0	26	27
2025	4	13	20	43	9	0.896	-0.059	3.205	0.016	0.013	0	57.2	58.5	65.8	160	164	0	27	28
2025	4	13	20	53	9	0.948	0	3.205	0.02	0.016	0	57.2	58.9	65.4	160	164	0	27	27
2025	4	13	21	3	9	0.948	-0.039	3.205	0.016	0.016	0	57.6	58.5	64.5	160	163	0	26	27
2025	4	13	21	13	9	0.948	-0.016	3.205	0.016	0.016	0	57.2	58.9	64.5	160	164	0	27	27
2025	4	13	21	23	9	0.928	-0.02	3.205	0.016	0.013	0	57.6	58.9	41.3	161	164	0	27	27
2025	4	13	21	33	9	0.915	-0.075	3.205	0.013	0.01	0	58	58.5	64.5	161	164	0	26	28
2025	4	13	21	43	9	0.942	-0.03	3.205	0.016	0.013	0	57.6	58.9	62.8	160	164	0	26	27
2025	4	13	21	53	9	0.925	-0.026	3.202	0.016	0.016	0	57.6	58.9	55.5	160	164	0	26	27
2025	4	13	22	3	9	0.928	-0.052	3.202	0.016	0.013	0	57.6	58.9	58.5	161	164	0	27	27
2025	4	13	22	13	9	0.938	-0.023	3.202	0.013	0.01	0	57.6	58.9	45.6	160	164	0	26	27
2025	4	13	22	23	9	0.915	-0.033	3.202	0.013	0.01	0	57.2	58.9	43	160	164	0	27	27
2025	4	13	22	33	9	0.896	0	3.202	0.016	0.016	0	58	58.9	47.3	161	164	0	26	27
2025	4	13	22	43	9	0.948	-0.007	3.199	0.016	0.016	0	57.2	58.9	48.6	160	164	0	27	27
2025	4	13	22	53	9	0.906	-0.01	3.199	0.013	0.01	0	58	58.9	64.1	161	164	0	26	27
2025	4	13	23	3	9	0.935	-0.043	3.199	0.02	0.016	0	57.2	58.9	63.2	160	164	0	27	27
2025	4	13	23	13	9	0.912	-0.052	3.199	0.016	0.013	0	57.6	58.9	62.8	161	164	0	27	27
2025	4	13	23	23	9	0.932	-0.043	3.199	0.016	0.013	0	57.2	58.5	63.6	160	163	0	27	27
2025	4	13	23	33	9	0.919	-0.03	3.199	0.016	0.016	0	57.2	58.5	64.9	160	163	0	27	27
2025	4	13	23	43	9	0.938	-0.036	3.196	0.013	0.01	0	57.2	58.5	64.9	160	163	0	27	27
2025	4	13	23	53	9	0.909	-0.039	3.196	0.016	0.016	0	57.6	58.9	66.2	161	164	0	27	27

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	14	0	3	9	0.948	-0.03	3.196	0.016	0.013	0	57.2	58.9	66.2	160	164	0	27	27
2025	4	14	0	13	9	0.912	-0.079	3.196	0.016	0.016	0	56.8	58.9	65.8	160	164	0	28	27
2025	4	14	0	23	9	0.922	-0.052	3.196	0.016	0.013	0	57.6	59.3	66.2	160	164	0	26	26
2025	4	14	0	33	9	0.945	-0.03	3.192	0.013	0.01	0	57.6	59.3	65.8	161	165	0	27	27
2025	4	14	0	43	9	0.902	-0.016	3.192	0.016	0.016	0	57.2	58.9	65.8	160	164	0	27	27
2025	4	14	0	53	9	0.932	-0.02	3.192	0.016	0.013	0	57.2	59.3	65.8	160	165	0	27	27
2025	4	14	1	3	9	0.925	0	3.192	0.02	0.016	0	57.2	58.9	66.7	160	165	0	27	28
2025	4	14	1	13	9	0.909	-0.013	3.192	0.016	0.013	0	57.2	58.9	65.8	160	165	0	27	28
2025	4	14	1	23	9	0.938	-0.026	3.192	0.016	0.013	0	57.2	58.9	66.2	160	164	0	27	27
2025	4	14	1	33	9	0.915	-0.026	3.192	0.016	0.013	0	57.2	58.9	65.4	160	164	0	27	27
2025	4	14	1	43	9	0.912	-0.066	3.189	0.013	0.01	0	57.6	58.9	65.8	160	164	0	26	27
2025	4	14	1	53	9	0.942	-0.026	3.189	0.016	0.013	0	57.6	59.3	62.4	161	165	0	27	27
2025	4	14	2	3	9	0.883	-0.036	3.189	0.016	0.013	0	57.2	58.9	62.4	160	165	0	27	28
2025	4	14	2	13	9	0.899	-0.043	3.189	0.013	0.01	0	57.6	59.3	66.2	161	165	0	27	27
2025	4	14	2	23	9	0.935	-0.013	3.189	0.016	0.016	0	57.6	58.9	64.1	161	164	0	27	27
2025	4	14	2	33	9	0.925	-0.043	3.189	0.016	0.016	0	57.6	59.3	64.5	161	165	0	27	27
2025	4	14	2	43	9	0.906	-0.026	3.186	0.016	0.013	0	57.6	58.9	59.8	161	164	0	27	27
2025	4	14	2	53	9	0.876	-0.016	3.186	0.016	0.013	0	58	59.3	55.5	162	165	0	27	27
2025	4	14	3	3	9	0.932	-0.01	3.186	0.016	0.013	0	57.6	58.9	65.8	161	164	0	27	27
2025	4	14	3	13	9	0.932	-0.02	3.186	0.013	0.01	0	57.6	58.9	60.2	161	165	0	27	28
2025	4	14	3	23	9	0.928	-0.013	3.186	0.013	0.01	0	57.6	58.9	62.8	161	165	0	27	28
2025	4	14	3	33	9	0.879	-0.033	3.186	0.016	0.013	0	57.6	59.3	59.8	161	165	0	27	27
2025	4	14	3	43	9	0.935	-0.02	3.186	0.01	0.007	0	57.6	58.5	55.5	161	164	0	27	28
2025	4	14	3	53	9	0.965	-0.049	3.182	0.013	0.01	0	57.6	58.9	48.2	161	165	0	27	28
2025	4	14	4	3	9	0.889	-0.056	3.182	0.01	0.007	0	57.6	59.3	52.9	161	165	0	27	27
2025	4	14	4	13	9	0.899	-0.039	3.182	0.016	0.013	0	58	59.3	50.7	162	165	0	27	27
2025	4	14	4	23	9	0.922	-0.013	3.182	0.016	0.013	0	57.6	59.3	43.4	161	165	0	27	27
2025	4	14	4	33	9	0.899	-0.043	3.182	0.016	0.016	0	57.6	59.3	46	161	165	0	27	27
2025	4	14	4	43	9	0.899	-0.023	3.182	0.013	0.01	0	57.6	58.9	44.7	161	165	0	27	28
2025	4	14	4	53	9	0.919	-0.043	3.182	0.016	0.013	0	58	58.9	43.4	161	165	0	26	28
2025	4	14	5	3	9	0.899	-0.03	3.182	0.016	0.013	0	57.6	59.3	44.3	161	165	0	27	27
2025	4	14	5	13	9	0.942	-0.072	3.179	0.013	0.01	0	58	59.3	43.4	162	165	0	27	27
2025	4	14	5	23	9	0.899	-0.033	3.179	0.016	0.016	0	58.5	59.8	55.9	163	166	0	27	27
2025	4	14	5	33	9	0.909	-0.052	3.182	0.013	0.01	0	58	59.3	48.6	162	166	0	27	28
2025	4	14	5	43	9	0.909	-0.056	3.179	0.013	0.01	0	57.6	59.3	65.8	161	165	0	27	27
2025	4	14	5	53	9	0.915	-0.066	3.179	0.016	0.013	0	58	59.3	65.4	161	165	0	26	27
2025	4	14	6	3	9	0.902	-0.052	3.179	0.01	0.007	0	58	58.9	64.9	162	165	0	27	28
2025	4	14	6	13	9	0.925	-0.049	3.179	0.016	0.013	0	58	59.3	65.8	162	165	0	27	27
2025	4	14	6	23	9	0.889	-0.033	3.179	0.016	0.013	0	58	59.3	65.4	162	165	0	27	27
2025	4	14	6	33	9	0.938	-0.026	3.179	0.016	0.013	0	57.2	58.9	65.8	161	165	0	28	28
2025	4	14	6	43	9	0.866	-0.033	3.179	0.016	0.016	0	58.5	59.3	65.8	163	166	0	27	28
2025	4	14	6	53	9	0.909	-0.056	3.179	0.016	0.013	0	58.5	59.8	65.4	163	166	0	27	27
2025	4	14	7	3	9	0.889	-0.056	3.179	0.02	0.016	0	56.8	59.3	65.8	159	166	0	27	28
2025	4	14	7	13	9	0.925	-0.03	3.176	0.013	0.01	0	56.8	59.8	48.2	159	166	0	27	27
2025	4	14	7	23	9	0.892	-0.052	3.179	0.013	0.01	0	56.8	58.9	64.9	159	165	0	27	28
2025	4	14	7	33	9	0.919	-0.062	3.179	0.013	0.01	0	57.2	59.3	63.6	160	165	0	27	27
2025	4	14	7	43	9	0.922	0	3.176	0.013	0.01	0	56.8	58.9	59.3	159	165	0	27	28
2025	4	14	7	53	9	0.912	-0.03	3.179	0.016	0.013	0	57.2	59.3	64.1	159	165	0	26	27

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	14	8	3	9	0.883	-0.016	3.176	0.016	0.013	0	56.8	59.8	65.4	159	166	0	27	27
2025	4	14	8	13	9	0.906	-0.075	3.179	0.016	0.013	0	57.2	58.9	65.4	159	165	0	26	28
2025	4	14	8	23	9	0.938	-0.03	3.179	0.016	0.016	0	56.3	59.3	63.6	158	165	0	27	27
2025	4	14	8	33	9	0.906	-0.039	3.176	0.016	0.013	0	57.2	59.3	50.7	159	166	0	26	28
2025	4	14	8	43	9	0.919	-0.046	3.179	0.016	0.013	0	57.2	59.8	62.8	159	166	0	26	27
2025	4	14	8	53	9	0.906	-0.03	3.176	0.016	0.013	0	56.8	59.3	44.3	159	166	0	27	28
2025	4	14	9	3	9	0.915	-0.023	3.179	0.016	0.016	0	56.3	59.3	43	158	165	0	27	27
2025	4	14	9	13	9	0.965	-0.043	3.179	0.016	0.013	0	56.3	59.8	45.6	158	166	0	27	27
2025	4	14	9	23	9	0.942	-0.046	3.179	0.016	0.016	0	56.3	59.3	46.4	158	166	0	27	28
2025	4	14	9	33	9	0.876	-0.046	3.179	0.013	0.01	0	56.3	59.3	56.3	158	166	0	27	28
2025	4	14	9	43	9	0.863	-0.007	3.176	0.016	0.013	0	58.5	59.3	46.4	163	166	0	27	28
2025	4	14	9	53	9	0.938	-0.03	3.179	0.016	0.013	0	57.6	59.3	55	162	165	0	28	27
2025	4	14	10	3	9	0.912	-0.039	3.179	0.016	0.013	0	58.5	59.8	52	163	166	0	27	27
2025	4	14	10	13	9	0.889	-0.043	3.179	0.016	0.013	0	58	59.3	57.6	162	166	0	27	28
2025	4	14	10	23	9	0.896	-0.059	3.179	0.016	0.013	0	58	59.3	60.2	162	166	0	27	28
2025	4	14	10	33	9	0.896	-0.033	3.179	0.013	0.01	0	58.5	59.8	61.9	163	166	0	27	27
2025	4	14	10	43	9	0.892	-0.016	3.176	0.016	0.013	0	58.5	59.8	56.3	163	166	0	27	27
2025	4	14	10	53	9	0.919	-0.033	3.176	0.013	0.01	0	58	59.8	60.2	162	166	0	27	27
2025	4	14	11	3	9	0.935	-0.059	3.176	0.016	0.013	0	58.5	58.9	62.8	162	165	0	26	28
2025	4	14	11	13	9	0.925	-0.049	3.173	0.013	0.01	0	57.6	59.8	55.5	161	166	0	27	27
2025	4	14	11	23	9	0.919	-0.007	3.173	0.016	0.016	0	58	59.3	61.9	162	165	0	27	27
2025	4	14	11	33	9	0.942	-0.072	3.173	0.013	0.01	0	58	59.8	62.4	162	166	0	27	27
2025	4	14	11	43	9	0.945	-0.023	3.169	0.016	0.016	0	58	59.8	45.6	162	166	0	27	27
2025	4	14	11	53	9	0.886	-0.02	3.169	0.013	0.01	0	58.5	59.8	49.9	162	166	0	26	27
2025	4	14	12	3	9	0.896	-0.062	3.169	0.016	0.013	0	58	59.3	56.3	162	166	0	27	28
2025	4	14	12	13	9	0.899	-0.033	3.169	0.016	0.016	0	58	59.8	52	162	166	0	27	27
2025	4	14	12	23	9	0.928	-0.075	3.169	0.016	0.013	0	58	58.9	54.6	162	165	0	27	28
2025	4	14	12	33	9	0.899	-0.007	3.169	0.016	0.016	0	58	60.2	43	162	166	0	27	26
2025	4	14	12	43	9	0.925	-0.039	3.169	0.013	0.01	0	58	59.8	61.5	162	166	0	27	27
2025	4	14	12	53	9	0.925	-0.046	3.169	0.013	0.01	0	58	59.3	60.2	162	165	0	27	27
2025	4	14	13	3	9	0.879	-0.023	3.169	0.016	0.013	0	58.5	59.3	60.6	163	166	0	27	28
2025	4	14	13	13	9	0.938	-0.013	3.169	0.013	0.01	0	58.5	59.8	46	162	166	0	26	27
2025	4	14	13	23	9	0.945	-0.01	3.169	0.016	0.013	0	58	59.8	54.2	162	166	0	27	27
2025	4	14	13	33	9	0.919	-0.043	3.173	0.016	0.016	0	57.6	59.3	41.7	161	165	0	27	27
2025	4	14	13	43	9	0.909	-0.036	3.179	0.016	0.013	0	58.5	59.3	39.6	162	165	0	26	27
2025	4	14	13	53	9	0.906	-0.016	3.173	0.016	0.016	0	58.9	59.8	44.3	163	166	0	26	27
2025	4	14	14	3	9	0.912	-0.016	3.173	0.02	0.016	0	58	59.8	36.1	162	166	0	27	27
2025	4	14	14	13	9	0.915	-0.016	3.176	0.016	0.013	0	58.5	59.8	38.7	162	166	0	26	27
2025	4	14	14	23	9	0.915	0.003	3.173	0.016	0.016	0	58.5	60.2	41.7	163	166	0	27	26
2025	4	14	14	33	9	0.909	-0.016	3.173	0.016	0.013	0	58.9	47.7	43.9	163	139	0	26	28
2025	4	14	14	43	9	0.899	-0.003	3.173	0.016	0.013	0	58	56.3	40.9	162	159	0	27	28
2025	4	14	14	53	9	0.945	-0.016	3.176	0.016	0.013	0	58	56.3	38.7	162	158	0	27	27
2025	4	14	15	3	9	0.935	-0.023	3.176	0.016	0.013	0	58.5	54.6	41.3	162	154	0	26	27
2025	4	14	15	13	9	0.896	-0.016	3.176	0.016	0.016	0	58.5	55	39.6	162	155	0	26	27
2025	4	14	15	23	9	0.902	-0.046	3.176	0.016	0.013	0	58.5	54.6	61.9	162	154	0	26	27
2025	4	14	15	33	9	0.938	-0.013	3.176	0.016	0.016	0	58.5	55	52.5	162	154	0	26	26
2025	4	14	15	43	9	0.958	-0.052	3.176	0.016	0.013	0	58.5	57.2	37	162	160	0	26	27
2025	4	14	15	53	9	0.922	-0.075	3.176	0.016	0.013	0	58	58.5	62.4	161	163	0	26	27

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	14	16	3	9	0.912	-0.049	3.176	0.013	0.01	0	58.5	59.3	43.9	162	165	0	26	27
2025	4	14	16	13	9	0.925	-0.052	3.179	0.016	0.016	0	58.5	57.6	41.7	162	161	0	26	27
2025	4	14	16	23	9	0.942	-0.01	3.179	0.013	0.01	0	57.6	58.9	40.9	161	164	0	27	27
2025	4	14	16	33	9	0.942	-0.03	3.179	0.02	0.016	0	58.5	59.3	40	162	165	0	26	27
2025	4	14	16	43	9	0.942	-0.003	3.179	0.013	0.01	0	58.9	58.9	40	163	165	0	26	28
2025	4	14	16	53	9	0.928	-0.03	3.179	0.02	0.016	0	58.9	58.9	41.3	163	163	0	26	26
2025	4	14	17	3	9	0.886	-0.013	3.179	0.016	0.016	0	58	57.6	40.4	162	161	0	27	27
2025	4	14	17	13	9	0.925	-0.043	3.179	0.016	0.013	0	58	57.6	38.3	161	160	0	26	26
2025	4	14	17	23	9	0.899	-0.026	3.179	0.016	0.013	0	58.5	54.2	40.4	162	153	0	26	27
2025	4	14	17	33	9	0.906	-0.016	3.176	0.016	0.013	0	58.5	53.3	45.2	162	151	0	26	27
2025	4	14	17	43	9	0.892	-0.03	3.179	0.016	0.013	0	57.6	51.2	60.6	161	146	0	27	27
2025	4	14	17	53	9	0.909	-0.043	3.179	0.016	0.013	0	57.6	55.9	64.5	161	157	0	27	27
2025	4	14	18	3	9	0.912	0	3.179	0.016	0.013	0	58.5	58.9	64.5	162	164	0	26	27
2025	4	14	18	13	9	0.942	-0.01	3.179	0.016	0.016	0	58.5	58.9	63.6	162	163	0	26	26
2025	4	14	18	23	9	0.951	-0.013	3.179	0.016	0.016	0	58	58.9	64.1	161	164	0	26	27
2025	4	14	18	33	9	0.879	-0.056	3.179	0.016	0.013	0	58	59.3	64.1	161	165	0	26	27
2025	4	14	18	43	9	0.932	-0.046	3.179	0.013	0.01	0	57.6	59.3	63.6	161	165	0	27	27
2025	4	14	18	53	9	0.892	-0.016	3.179	0.016	0.013	0	57.6	59.8	63.6	161	166	0	27	27
2025	4	14	19	3	9	0.909	-0.043	3.179	0.016	0.013	0	58.5	59.8	64.1	162	165	0	26	26
2025	4	14	19	13	9	0.876	-0.016	3.179	0.01	0.007	0	58.9	59.8	63.2	163	166	0	26	27
2025	4	14	19	23	9	0.906	-0.023	3.179	0.016	0.013	0	58.5	59.3	63.2	163	165	0	27	27
2025	4	14	19	33	9	0.935	-0.013	3.179	0.01	0.007	0	58	59.3	63.6	162	165	0	27	27
2025	4	14	19	43	9	0.932	0	3.179	0.016	0.016	0	58.5	59.8	62.8	162	165	0	26	26
2025	4	14	19	53	9	0.948	-0.033	3.179	0.016	0.013	0	58.5	59.3	63.2	162	165	0	26	27
2025	4	14	20	3	9	0.902	-0.013	3.179	0.013	0.01	0	58	58.9	62.8	162	165	0	27	28
2025	4	14	20	13	9	0.945	-0.03	3.179	0.013	0.01	0	58	59.8	62.8	162	165	0	27	26
2025	4	14	20	23	9	0.915	-0.003	3.182	0.016	0.016	0	58	59.3	62.4	162	165	0	27	27
2025	4	14	20	33	9	0.915	-0.03	3.182	0.02	0.016	0	58.9	59.8	62.4	162	165	0	25	26
2025	4	14	20	43	9	0.899	-0.043	3.182	0.016	0.013	0	58.5	59.3	62.8	162	165	0	26	27
2025	4	14	20	53	9	0.906	-0.007	3.186	0.016	0.013	0	58	59.3	62.4	162	165	0	27	27
2025	4	14	21	3	9	0.928	-0.039	3.186	0.013	0.01	0	58	59.8	62.8	162	165	0	27	26
2025	4	14	21	13	9	0.889	-0.023	3.186	0.016	0.013	0	57.6	58.9	62.4	161	164	0	27	27
2025	4	14	21	23	9	0.912	-0.052	3.189	0.016	0.016	0	58	59.3	63.2	161	165	0	26	27
2025	4	14	21	33	9	0.932	-0.016	3.186	0.016	0.013	0	57.6	58.9	62.4	161	164	0	27	27
2025	4	14	21	43	9	0.945	-0.03	3.186	0.016	0.013	0	57.6	58.5	63.2	161	164	0	27	28
2025	4	14	21	53	9	0.932	-0.03	3.189	0.02	0.016	0	57.2	58.9	63.6	160	164	0	27	27
2025	4	14	22	3	9	0.915	-0.016	3.186	0.013	0.01	0	57.6	58.9	62.8	161	164	0	27	27
2025	4	14	22	13	9	0.899	-0.03	3.186	0.016	0.013	0	57.2	58.9	61.9	160	164	0	27	27
2025	4	14	22	23	9	0.919	-0.03	3.186	0.01	0.007	0	58	58.9	63.6	161	164	0	26	27
2025	4	14	22	33	9	0.909	-0.03	3.186	0.016	0.013	0	57.6	58.9	62.8	161	164	0	27	27
2025	4	14	22	43	9	0.912	-0.03	3.189	0.01	0.007	0	58	58.5	62.8	161	163	0	26	27
2025	4	14	22	53	9	0.932	-0.046	3.186	0.016	0.013	0	58	58	63.2	161	162	0	26	27
2025	4	14	23	3	9	0.919	-0.03	3.189	0.013	0.01	0	57.6	59.3	63.2	161	164	0	27	26
2025	4	14	23	13	9	0.928	0.026	3.186	0.01	0.007	0	58	58.9	63.2	161	164	0	26	27
2025	4	14	23	23	9	0.866	-0.013	3.189	0.016	0.016	0	58	58.5	64.1	161	164	0	26	28
2025	4	14	23	33	9	0.925	0	3.186	0.013	0.01	0	57.6	58.9	64.5	160	164	0	26	27
2025	4	14	23	43	9	0.886	-0.01	3.186	0.016	0.013	0	57.6	58.9	64.5	161	164	0	27	27
2025	4	14	23	53	9	0.892	-0.039	3.186	0.016	0.013	0	57.6	58.5	64.5	161	164	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	15	0	3	9	0.932	-0.059	3.186	0.016	0.013	0	58	58.9	64.1	161	164	0	26	27
2025	4	15	0	13	9	0.958	-0.043	3.186	0.016	0.013	0	57.2	58	65.4	160	163	0	27	28
2025	4	15	0	23	9	0.928	-0.026	3.186	0.013	0.01	0	57.6	59.3	65.4	161	165	0	27	27
2025	4	15	0	33	9	0.915	0	3.186	0.02	0.016	0	57.6	59.3	64.9	161	165	0	27	27
2025	4	15	0	43	9	0.922	-0.02	3.186	0.016	0.013	0	57.6	59.3	64.9	161	165	0	27	27
2025	4	15	0	53	9	0.899	-0.036	3.186	0.016	0.016	0	57.6	59.3	65.4	161	165	0	27	27
2025	4	15	1	3	9	0.892	-0.013	3.186	0.016	0.013	0	57.2	59.3	65.8	160	165	0	27	27
2025	4	15	1	13	9	0.912	-0.043	3.186	0.016	0.016	0	57.2	58.9	65.4	160	164	0	27	27
2025	4	15	1	23	9	0.886	0	3.186	0.016	0.013	0	57.2	59.3	65.4	160	165	0	27	27
2025	4	15	1	33	9	0.922	-0.039	3.186	0.013	0.01	0	57.6	59.3	65.4	160	165	0	26	27
2025	4	15	1	43	9	0.932	-0.02	3.186	0.013	0.01	0	57.2	59.3	65.8	160	165	0	27	27
2025	4	15	1	53	9	0.925	0	3.186	0.016	0.013	0	56.8	58.9	65.8	160	165	0	28	28
2025	4	15	2	3	9	0.909	-0.003	3.186	0.02	0.016	0	56.8	59.3	66.2	159	165	0	27	27
2025	4	15	2	13	9	0.919	-0.039	3.186	0.013	0.01	0	57.2	58.9	65.8	160	165	0	27	28
2025	4	15	2	23	9	0.876	-0.043	3.186	0.016	0.016	0	57.6	59.3	65.8	160	165	0	26	27
2025	4	15	2	33	9	0.925	-0.013	3.186	0.016	0.013	0	57.2	58.9	64.9	160	164	0	27	27
2025	4	15	2	43	9	0.912	-0.007	3.186	0.016	0.013	0	57.2	59.3	65.8	160	165	0	27	27
2025	4	15	2	53	9	0.915	-0.052	3.182	0.016	0.016	0	57.2	58.9	65.8	160	164	0	27	27
2025	4	15	3	3	9	0.909	-0.036	3.186	0.016	0.013	0	57.6	58.9	66.2	161	164	0	27	27
2025	4	15	3	13	9	0.883	-0.046	3.182	0.016	0.016	0	57.6	58.9	65.8	161	165	0	27	28
2025	4	15	3	23	9	0.948	-0.026	3.182	0.016	0.013	0	57.6	58.9	66.2	160	164	0	26	27
2025	4	15	3	33	9	0.896	-0.039	3.182	0.013	0.01	0	57.6	59.3	64.5	161	165	0	27	27
2025	4	15	3	43	9	0.942	0	3.182	0.016	0.013	0	57.6	59.3	65.8	161	165	0	27	27
2025	4	15	3	53	9	0.925	-0.02	3.182	0.016	0.013	0	57.6	59.3	66.2	160	165	0	26	27
2025	4	15	4	3	9	0.912	-0.039	3.182	0.016	0.013	0	56.8	58.9	66.7	160	164	0	28	27
2025	4	15	4	13	9	0.948	-0.033	3.182	0.016	0.013	0	57.6	58.9	66.7	160	164	0	26	27
2025	4	15	4	23	9	0.951	-0.003	3.182	0.016	0.016	0	57.6	59.3	66.7	160	165	0	26	27
2025	4	15	4	33	9	0.928	-0.059	3.182	0.013	0.01	0	57.2	59.3	66.2	160	165	0	27	27
2025	4	15	4	43	9	0.928	-0.03	3.182	0.01	0.007	0	57.2	59.3	66.7	160	165	0	27	27
2025	4	15	4	53	9	0.899	-0.043	3.182	0.016	0.013	0	57.2	58.9	66.2	160	165	0	27	28
2025	4	15	5	3	9	0.922	-0.082	3.182	0.016	0.013	0	57.6	55.9	67.1	161	157	0	27	27
2025	4	15	5	13	9	0.919	-0.052	3.182	0.016	0.013	0	58	54.2	65.8	161	153	0	26	27
2025	4	15	5	23	9	0.968	-0.056	3.182	0.013	0.01	0	58.5	54.6	66.2	162	154	0	26	27
2025	4	15	5	33	9	0.892	-0.03	3.182	0.016	0.013	0	57.6	54.2	66.2	161	153	0	27	27
2025	4	15	5	43	9	0.978	-0.036	3.179	0.016	0.013	0	57.6	53.3	66.2	161	152	0	27	28
2025	4	15	5	53	9	0.942	-0.066	3.182	0.013	0.01	0	57.6	54.2	66.7	160	153	0	26	27
2025	4	15	6	3	9	0.906	-0.016	3.179	0.013	0.01	0	57.6	55	66.2	161	156	0	27	28
2025	4	15	6	13	9	0.915	-0.03	3.179	0.013	0.01	0	57.6	56.3	66.7	161	158	0	27	27
2025	4	15	6	23	9	0.938	-0.023	3.179	0.013	0.01	0	57.6	55.5	66.2	162	156	0	28	27
2025	4	15	6	33	9	0.909	-0.03	3.179	0.013	0.01	0	58	55	66.2	162	156	0	27	28
2025	4	15	6	43	9	0.942	-0.082	3.179	0.016	0.013	0	57.6	58	66.2	161	163	0	27	28
2025	4	15	6	53	9	0.866	-0.013	3.179	0.013	0.01	0	58.5	56.3	65.8	162	158	0	26	27
2025	4	15	7	3	9	0.883	-0.033	3.179	0.016	0.013	0	58	58.5	66.2	162	164	0	27	28
2025	4	15	7	13	9	0.892	-0.026	3.179	0.013	0.01	0	58.5	56.8	66.7	162	160	0	26	28
2025	4	15	7	23	9	0.879	-0.043	3.179	0.016	0.016	0	58	55.9	66.2	162	157	0	27	27
2025	4	15	7	33	9	0.909	-0.003	3.179	0.016	0.013	0	58.5	57.6	66.7	163	162	0	27	28
2025	4	15	7	43	9	0.919	-0.046	3.179	0.016	0.013	0	58.5	58.5	66.7	163	163	0	27	27
2025	4	15	7	53	9	0.912	-0.03	3.179	0.01	0.007	0	58	58.9	66.7	162	164	0	27	27

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	15	8	3	9	0.909	-0.016	3.179	0.016	0.013	0	58	58.9	66.2	162	164	0	27	27
2025	4	15	8	13	9	0.909	-0.059	3.182	0.016	0.016	0	58	58.9	67.1	162	164	0	27	27
2025	4	15	8	23	9	0.912	-0.007	3.182	0.016	0.016	0	58.5	58.9	66.7	163	165	0	27	28
2025	4	15	8	33	9	0.856	-0.033	3.182	0.016	0.016	0	58	59.3	66.2	162	165	0	27	27
2025	4	15	8	43	9	0.902	-0.043	3.182	0.013	0.01	0	58	59.8	65.8	162	166	0	27	27
2025	4	15	8	53	9	0.922	-0.03	3.182	0.016	0.013	0	58	59.8	66.2	162	166	0	27	27
2025	4	15	9	3	9	0.932	-0.056	3.182	0.016	0.013	0	58	58.9	65.4	162	165	0	27	28
2025	4	15	9	13	9	0.896	-0.023	3.182	0.016	0.013	0	57.6	58.9	65.8	161	165	0	27	28
2025	4	15	9	23	9	0.912	-0.016	3.182	0.016	0.016	0	57.6	59.3	65.8	161	165	0	27	27
2025	4	15	9	33	9	0.925	-0.003	3.182	0.016	0.016	0	57.6	58	65.8	161	163	0	27	28
2025	4	15	9	43	9	0.889	-0.007	3.182	0.013	0.01	0	57.6	59.3	65.4	161	165	0	27	27
2025	4	15	9	53	9	0.912	-0.016	3.176	0.013	0.01	0	57.6	58.9	43.4	161	165	0	27	28
2025	4	15	10	3	9	0.915	-0.013	3.179	0.016	0.016	0	57.6	59.3	45.6	161	165	0	27	27
2025	4	15	10	13	9	0.919	-0.039	3.176	0.013	0.01	0	57.6	58.9	40.4	161	164	0	27	27
2025	4	15	10	23	9	0.919	-0.033	3.179	0.013	0.01	0	57.2	58.9	41.7	160	165	0	27	28
2025	4	15	10	33	9	0.922	-0.036	3.173	0.016	0.016	0	57.6	59.3	40.9	160	165	0	26	27
2025	4	15	10	43	9	0.942	-0.023	3.169	0.016	0.013	0	58	59.8	38.3	162	166	0	27	27
2025	4	15	10	53	9	0.932	-0.052	3.176	0.016	0.013	0	58	59.3	39.6	162	165	0	27	27
2025	4	15	11	3	9	0.942	-0.043	3.176	0.016	0.016	0	58	58.9	39.6	162	165	0	27	28
2025	4	15	11	13	9	0.925	-0.023	3.176	0.013	0.01	0	58.5	59.8	39.1	162	166	0	26	27
2025	4	15	11	23	9	0.896	-0.02	3.176	0.016	0.013	0	58.9	59.8	39.1	163	166	0	26	27
2025	4	15	11	33	9	0.955	-0.03	3.179	0.016	0.013	0	58	59.3	40	162	165	0	27	27
2025	4	15	11	43	9	0.935	-0.039	3.173	0.016	0.013	0	58	59.3	40.4	162	165	0	27	27
2025	4	15	11	53	9	0.902	0.013	3.176	0.016	0.013	0	58	59.3	39.1	162	165	0	27	27
2025	4	15	12	3	9	0.938	-0.013	3.176	0.013	0.01	0	58.5	59.3	39.6	163	166	0	27	28
2025	4	15	12	13	9	0.909	-0.039	3.176	0.016	0.016	0	58.5	59.3	39.1	162	165	0	26	27
2025	4	15	12	23	9	0.915	-0.007	3.173	0.016	0.013	0	58	59.3	41.3	162	165	0	27	27
2025	4	15	12	33	9	0.951	0	3.176	0.016	0.013	0	58	59.3	38.3	162	165	0	27	27
2025	4	15	12	43	9	0.925	-0.03	3.179	0.013	0.01	0	58.5	59.3	40.9	162	165	0	26	27
2025	4	15	12	53	9	0.906	-0.033	3.176	0.016	0.013	0	58	59.3	38.7	162	165	0	27	27
2025	4	15	13	3	9	0.906	-0.059	3.176	0.016	0.013	0	58.9	60.2	38.3	163	166	0	26	26
2025	4	15	13	13	9	0.928	-0.059	3.176	0.016	0.016	0	58.5	59.3	40.9	162	165	0	26	27
2025	4	15	13	23	9	0.919	-0.062	3.176	0.016	0.013	0	58.5	59.3	41.7	163	166	0	27	28
2025	4	15	13	33	9	0.915	0	3.176	0.016	0.016	0	58.5	59.8	42.6	163	166	0	27	27
2025	4	15	13	43	9	0.912	-0.016	3.179	0.016	0.016	0	58.5	59.8	38.7	163	166	0	27	27
2025	4	15	13	53	9	0.883	0.01	3.176	0.016	0.016	0	58.9	59.8	43.4	163	166	0	26	27
2025	4	15	14	3	9	0.948	-0.02	3.176	0.016	0.013	0	58.9	59.8	41.7	163	166	0	26	27
2025	4	15	14	13	9	0.906	-0.013	3.176	0.016	0.013	0	58.5	59.8	40	163	166	0	27	27
2025	4	15	14	23	9	0.912	-0.039	3.176	0.016	0.013	0	58.5	60.2	43.4	163	167	0	27	27
2025	4	15	14	33	9	0.902	-0.01	3.176	0.016	0.013	0	58.9	60.2	40.4	163	166	0	26	26
2025	4	15	14	43	9	0.892	-0.043	3.176	0.016	0.013	0	58.9	59.8	40.9	163	166	0	26	27
2025	4	15	14	53	9	0.899	-0.043	3.179	0.013	0.01	0	58.9	60.2	40.4	163	167	0	26	27
2025	4	15	15	3	9	0.935	-0.046	3.182	0.016	0.013	0	58.9	60.2	37.8	163	167	0	26	27
2025	4	15	15	13	9	0.889	-0.026	3.179	0.016	0.016	0	58.9	60.2	39.6	163	167	0	26	27
2025	4	15	15	23	9	0.935	-0.023	3.176	0.013	0.01	0	58.5	60.2	41.3	163	167	0	27	27
2025	4	15	15	33	9	0.919	-0.03	3.179	0.016	0.013	0	58.5	59.8	40.4	163	166	0	27	27
2025	4	15	15	43	9	0.86	-0.046	3.179	0.016	0.013	0	58.5	60.2	38.7	163	167	0	27	27
2025	4	15	15	53	9	0.951	-0.039	3.182	0.016	0.013	0	58.5	59.8	38.7	163	166	0	27	27

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	15	16	3	9	0.945	-0.016	3.182	0.016	0.013	0	58.9	59.8	37.8	163	166	0	26	27
2025	4	15	16	13	9	0.955	-0.023	3.179	0.016	0.016	0	58.5	59.8	38.7	163	166	0	27	27
2025	4	15	16	23	9	0.906	-0.046	3.182	0.016	0.016	0	58.5	59.3	38.7	162	166	0	26	28
2025	4	15	16	33	9	0.951	-0.062	3.179	0.016	0.016	0	58.9	59.8	40	163	166	0	26	27
2025	4	15	16	43	9	0.909	-0.039	3.179	0.016	0.013	0	58	59.8	38.7	162	166	0	27	27
2025	4	15	16	53	9	0.945	-0.033	3.179	0.016	0.013	0	58.9	60.2	40	162	166	0	25	26
2025	4	15	17	3	9	0.935	0	3.176	0.016	0.016	0	58	59.8	40.9	162	166	0	27	27
2025	4	15	17	13	9	0.925	-0.026	3.176	0.016	0.013	0	58	59.8	41.7	162	166	0	27	27
2025	4	15	17	23	9	0.892	-0.013	3.176	0.016	0.013	0	58	59.8	42.1	162	166	0	27	27
2025	4	15	17	33	9	0.909	-0.043	3.176	0.013	0.01	0	58.5	60.2	45.6	162	166	0	26	26
2025	4	15	17	43	9	0.928	-0.03	3.179	0.016	0.016	0	58.5	59.8	63.6	162	166	0	26	27
2025	4	15	17	53	9	0.906	-0.02	3.179	0.016	0.013	0	58	59.8	64.1	162	166	0	27	27
2025	4	15	18	3	9	0.919	-0.016	3.179	0.016	0.013	0	58	59.8	64.5	162	165	0	27	26
2025	4	15	18	13	9	0.922	-0.03	3.179	0.016	0.016	0	58.5	60.2	63.6	162	166	0	26	26
2025	4	15	18	23	9	0.892	-0.056	3.179	0.016	0.013	0	58.5	59.8	62.8	162	166	0	26	27
2025	4	15	18	33	9	0.948	-0.02	3.179	0.013	0.01	0	58	59.8	43.4	162	166	0	27	27
2025	4	15	18	43	9	0.935	-0.052	3.179	0.016	0.013	0	58.5	60.2	39.6	162	166	0	26	26
2025	4	15	18	53	9	0.942	-0.013	3.182	0.016	0.013	0	57.6	59.3	40.4	161	165	0	27	27
2025	4	15	19	3	9	0.928	-0.056	3.179	0.016	0.013	0	57.6	58.9	42.6	161	165	0	27	28
2025	4	15	19	13	9	0.889	-0.013	3.176	0.016	0.013	0	58.5	59.3	54.2	162	165	0	26	27
2025	4	15	19	23	9	0.919	-0.033	3.179	0.013	0.01	0	58	59.3	63.2	162	165	0	27	27
2025	4	15	19	33	9	0.928	-0.016	3.179	0.013	0.01	0	58	59.3	63.6	162	165	0	27	27
2025	4	15	19	43	9	0.935	-0.052	3.179	0.016	0.013	0	58.5	59.3	63.6	162	165	0	26	27
2025	4	15	19	53	9	0.951	-0.026	3.179	0.016	0.016	0	58	59.3	62.8	162	165	0	27	27
2025	4	15	20	3	9	0.922	0.016	3.179	0.016	0.013	0	58.5	59.3	62.8	162	165	0	26	27
2025	4	15	20	13	9	0.932	-0.036	3.179	0.016	0.016	0	58	59.3	62.8	162	165	0	27	27
2025	4	15	20	23	9	0.899	-0.03	3.179	0.016	0.013	0	58	59.3	63.2	162	165	0	27	27
2025	4	15	20	33	9	0.942	0.013	3.179	0.016	0.013	0	58.5	59.3	62.8	162	165	0	26	27
2025	4	15	20	43	9	0.938	0	3.179	0.016	0.013	0	58	59.3	62.8	162	165	0	27	27
2025	4	15	20	53	9	0.915	-0.039	3.176	0.016	0.013	0	58.5	59.8	63.2	162	166	0	26	27
2025	4	15	21	3	9	0.922	-0.013	3.176	0.016	0.013	0	58.5	59.3	63.2	162	165	0	26	27
2025	4	15	21	13	9	0.896	-0.023	3.176	0.016	0.013	0	58	59.3	63.2	162	165	0	27	27
2025	4	15	21	23	9	0.896	-0.052	3.176	0.013	0.01	0	58	59.3	63.6	161	164	0	26	26
2025	4	15	21	33	9	0.919	-0.013	3.176	0.016	0.013	0	58	59.3	62.8	161	164	0	26	26
2025	4	15	21	43	9	0.919	-0.036	3.176	0.016	0.013	0	57.6	58.9	63.2	161	164	0	27	27
2025	4	15	21	53	9	0.892	-0.052	3.176	0.013	0.01	0	58	58.9	62.8	161	164	0	26	27
2025	4	15	22	3	9	0.919	-0.013	3.176	0.016	0.013	0	58	59.3	62.4	161	165	0	26	27
2025	4	15	22	13	9	0.925	-0.046	3.176	0.016	0.016	0	58	58.9	63.2	161	164	0	26	27
2025	4	15	22	23	9	0.925	-0.059	3.176	0.016	0.013	0	58	59.3	62.8	161	165	0	26	27
2025	4	15	22	33	9	0.942	-0.03	3.176	0.013	0.01	0	58	58.5	62.8	161	163	0	26	27
2025	4	15	22	43	9	0.899	0.023	3.176	0.013	0.01	0	58	58.5	63.2	161	163	0	26	27
2025	4	15	22	53	9	0.909	-0.026	3.176	0.016	0.016	0	57.6	58.5	62.8	161	163	0	27	27
2025	4	15	23	3	9	0.928	-0.036	3.179	0.016	0.013	0	57.6	58.5	62.8	161	163	0	27	27
2025	4	15	23	13	9	0.922	-0.049	3.179	0.013	0.01	0	58	58	62.8	161	162	0	26	27
2025	4	15	23	23	9	0.909	-0.023	3.176	0.016	0.013	0	58	59.3	62.8	162	165	0	27	27
2025	4	15	23	33	9	0.935	-0.043	3.176	0.016	0.013	0	58	59.3	61.9	161	165	0	26	27
2025	4	15	23	43	9	0.932	-0.039	3.176	0.016	0.016	0	57.6	59.3	62.8	161	165	0	27	27
2025	4	15	23	53	9	0.886	-0.02	3.176	0.016	0.016	0	57.6	59.3	62.8	161	165	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	16	0	3	9	0.955	-0.03	3.176	0.013	0.01	0	57.6	58.9	61.9	161	164	0	27	27
2025	4	16	0	13	9	0.886	-0.03	3.179	0.016	0.013	0	58	59.8	61.9	161	165	0	26	26
2025	4	16	0	23	9	0.906	-0.03	3.179	0.016	0.013	0	57.6	59.3	62.4	161	165	0	27	27
2025	4	16	0	33	9	0.892	-0.046	3.179	0.013	0.01	0	58	59.3	62.8	161	165	0	26	27
2025	4	16	0	43	9	0.919	-0.066	3.179	0.013	0.01	0	58	58.9	63.2	161	164	0	26	27
2025	4	16	0	53	9	0.902	-0.033	3.179	0.016	0.016	0	58	59.3	62.4	161	165	0	26	27
2025	4	16	1	3	9	0.925	-0.049	3.179	0.016	0.013	0	57.6	58.9	62.4	161	165	0	27	28
2025	4	16	1	13	9	0.899	-0.085	3.179	0.013	0.01	0	57.6	59.3	62.4	161	165	0	27	27
2025	4	16	1	23	9	0.955	-0.036	3.179	0.016	0.016	0	57.6	59.3	63.2	161	165	0	27	27
2025	4	16	1	33	9	0.902	0	3.179	0.013	0.01	0	57.6	58.9	63.2	161	165	0	27	28
2025	4	16	1	43	9	0.899	-0.023	3.179	0.016	0.016	0	58	59.3	62.8	162	165	0	27	27
2025	4	16	1	53	9	0.955	-0.03	3.179	0.013	0.01	0	58	59.3	63.2	161	165	0	26	27
2025	4	16	2	3	9	0.912	-0.013	3.179	0.016	0.016	0	58	59.3	63.2	162	165	0	27	27
2025	4	16	2	13	9	0.955	-0.007	3.179	0.016	0.013	0	57.6	59.3	62.8	161	165	0	27	27
2025	4	16	2	23	9	0.925	-0.03	3.179	0.016	0.013	0	58	59.3	62.4	162	165	0	27	27
2025	4	16	2	33	9	0.902	-0.033	3.179	0.013	0.01	0	57.6	59.3	63.2	161	165	0	27	27
2025	4	16	2	43	9	0.892	-0.03	3.179	0.016	0.013	0	57.6	59.3	63.2	161	165	0	27	27
2025	4	16	2	53	9	0.922	-0.043	3.179	0.016	0.016	0	57.6	59.3	62.8	161	165	0	27	27
2025	4	16	3	3	9	0.922	-0.052	3.179	0.016	0.016	0	57.6	58.9	63.6	162	165	0	28	28
2025	4	16	3	13	9	0.902	-0.013	3.179	0.016	0.016	0	58	59.3	63.2	162	165	0	27	27
2025	4	16	3	23	9	0.879	-0.01	3.179	0.013	0.01	0	58	58.9	63.2	162	165	0	27	28
2025	4	16	3	33	9	0.909	-0.039	3.179	0.016	0.013	0	58	59.3	63.6	162	165	0	27	27
2025	4	16	3	43	9	0.909	-0.026	3.179	0.016	0.013	0	57.6	59.3	62.4	161	165	0	27	27
2025	4	16	3	53	9	0.925	-0.026	3.179	0.016	0.013	0	57.2	59.3	63.6	161	165	0	28	27
2025	4	16	4	3	9	0.899	-0.03	3.179	0.016	0.013	0	58	59.3	62.8	162	165	0	27	27
2025	4	16	4	13	9	0.909	-0.013	3.179	0.02	0.016	0	58	58.9	63.2	162	165	0	27	28
2025	4	16	4	23	9	0.942	-0.046	3.179	0.016	0.013	0	58	59.3	63.6	162	165	0	27	27
2025	4	16	4	33	9	0.892	-0.007	3.179	0.016	0.016	0	58	59.8	62.8	162	166	0	27	27
2025	4	16	4	43	9	0.928	-0.039	3.179	0.016	0.013	0	58.5	59.3	63.2	162	165	0	26	27
2025	4	16	4	53	9	0.899	-0.069	3.179	0.013	0.01	0	58	59.3	62.8	162	165	0	27	27
2025	4	16	5	3	9	0.902	-0.03	3.179	0.013	0.01	0	58	59.8	62.8	162	166	0	27	27
2025	4	16	5	13	9	0.932	-0.013	3.179	0.016	0.016	0	58	59.8	63.2	162	166	0	27	27
2025	4	16	5	23	9	0.909	-0.052	3.173	0.016	0.013	0	58	59.8	40	162	166	0	27	27
2025	4	16	5	33	9	0.876	-0.016	3.179	0.013	0.01	0	58.5	59.8	63.2	162	166	0	26	27
2025	4	16	5	43	9	0.876	-0.023	3.179	0.016	0.013	0	58.5	58.9	63.2	162	165	0	26	28
2025	4	16	5	53	9	0.886	-0.033	3.179	0.02	0.016	0	58	59.8	63.2	162	166	0	27	27
2025	4	16	6	3	9	0.906	-0.043	3.179	0.016	0.013	0	57.6	58.9	63.2	161	165	0	27	28
2025	4	16	6	13	9	0.915	-0.036	3.179	0.01	0.007	0	58	59.8	63.2	161	166	0	26	27
2025	4	16	6	23	9	0.935	-0.043	3.179	0.016	0.016	0	57.6	58.9	63.6	161	165	0	27	28
2025	4	16	6	33	9	0.906	-0.059	3.179	0.016	0.016	0	57.6	59.3	63.6	161	165	0	27	27
2025	4	16	6	43	9	0.899	-0.02	3.176	0.016	0.013	0	58	59.3	63.6	162	165	0	27	27
2025	4	16	6	53	9	0.896	-0.059	3.179	0.02	0.016	0	58	59.8	63.2	162	166	0	27	27
2025	4	16	7	3	9	0.919	-0.03	3.176	0.013	0.01	0	58	58.9	63.2	162	165	0	27	28
2025	4	16	7	13	9	0.902	-0.043	3.173	0.016	0.013	0	58	59.8	45.6	162	166	0	27	27
2025	4	16	7	23	9	0.912	-0.066	3.176	0.013	0.01	0	58	59.8	60.2	162	166	0	27	27
2025	4	16	7	33	9	0.866	-0.046	3.176	0.016	0.013	0	58.5	60.2	62.8	163	167	0	27	27
2025	4	16	7	43	9	0.892	-0.043	3.176	0.013	0.01	0	58.5	59.8	61.9	163	166	0	27	27
2025	4	16	7	53	9	0.896	-0.056	3.176	0.016	0.013	0	58	59.8	62.4	162	166	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	16	8	3	9	0.935	-0.043	3.173	0.013	0.01	0	57.6	59.3	61.5	162	166	0	28	28
2025	4	16	8	13	9	0.902	-0.043	3.173	0.016	0.016	0	58	59.3	60.2	162	166	0	27	28
2025	4	16	8	23	9	0.892	-0.046	3.173	0.016	0.013	0	58.5	59.8	61.5	163	166	0	27	27
2025	4	16	8	33	9	0.912	-0.072	3.173	0.016	0.013	0	58.9	59.3	61.1	163	166	0	26	28
2025	4	16	8	43	9	0.873	-0.043	3.173	0.016	0.013	0	58.5	59.8	59.3	163	166	0	27	27
2025	4	16	8	53	9	0.968	-0.043	3.169	0.016	0.013	0	58.5	59.3	61.9	163	165	0	27	27
2025	4	16	9	3	9	0.883	-0.026	3.169	0.02	0.016	0	58.5	59.8	61.5	163	166	0	27	27
2025	4	16	9	13	9	0.899	-0.01	3.169	0.016	0.013	0	58.9	59.8	47.7	163	166	0	26	27
2025	4	16	9	23	9	0.922	-0.03	3.169	0.013	0.01	0	58	59.8	58	162	166	0	27	27
2025	4	16	9	33	9	0.912	-0.03	3.166	0.016	0.013	0	58.5	59.8	50.3	163	166	0	27	27
2025	4	16	9	43	9	0.906	-0.059	3.166	0.016	0.013	0	58.9	59.3	54.2	163	166	0	26	28
2025	4	16	9	53	9	0.915	0	3.169	0.016	0.013	0	58.9	59.8	56.3	163	166	0	26	27
2025	4	16	10	3	9	0.912	-0.036	3.169	0.02	0.016	0	58	59.3	57.6	162	165	0	27	27
2025	4	16	10	13	9	0.909	0.013	3.169	0.016	0.013	0	58.5	59.8	55.5	163	166	0	27	27
2025	4	16	10	23	9	0.879	-0.036	3.169	0.016	0.013	0	58.5	59.8	61.1	163	166	0	27	27
2025	4	16	10	33	9	0.886	-0.02	3.169	0.013	0.01	0	58.9	59.8	61.1	163	166	0	26	27
2025	4	16	10	43	9	0.906	-0.003	3.169	0.013	0.01	0	58	59.8	46.4	163	166	0	28	27
2025	4	16	10	53	9	0.909	-0.039	3.169	0.016	0.013	0	58	59.3	56.8	162	165	0	27	27
2025	4	16	11	3	9	0.886	-0.01	3.169	0.013	0.01	0	58.9	59.8	55.5	163	166	0	26	27
2025	4	16	11	13	9	0.899	-0.046	3.169	0.013	0.01	0	58	59.3	55.5	162	165	0	27	27
2025	4	16	11	23	9	0.942	-0.056	3.169	0.013	0.01	0	58.5	59.8	56.8	163	166	0	27	27
2025	4	16	11	33	9	0.915	-0.039	3.169	0.013	0.01	0	58.9	59.8	58.5	163	166	0	26	27
2025	4	16	11	43	9	0.915	-0.046	3.173	0.016	0.013	0	58.9	59.8	65.4	163	166	0	26	27
2025	4	16	11	53	9	0.915	-0.062	3.169	0.016	0.013	0	58.5	60.2	50.7	163	167	0	27	27
2025	4	16	12	3	9	0.915	-0.023	3.173	0.013	0.01	0	58.5	59.8	52	163	166	0	27	27
2025	4	16	12	13	9	0.902	-0.059	3.173	0.016	0.016	0	58.9	59.8	62.4	163	166	0	26	27
2025	4	16	12	23	9	0.909	-0.059	3.173	0.016	0.013	0	58.9	60.2	61.9	163	166	0	26	26
2025	4	16	12	33	9	0.928	-0.016	3.173	0.016	0.016	0	58.9	59.8	63.2	163	166	0	26	27
2025	4	16	12	43	9	0.925	-0.026	3.173	0.016	0.013	0	58.9	60.2	49.9	163	166	0	26	26
2025	4	16	12	53	9	0.912	-0.007	3.173	0.02	0.016	0	58.5	59.8	64.9	163	166	0	27	27
2025	4	16	13	3	9	0.883	-0.01	3.173	0.016	0.013	0	58.9	59.8	43.4	163	166	0	26	27
2025	4	16	13	13	9	0.909	-0.043	3.176	0.016	0.013	0	58.9	59.8	40.4	163	166	0	26	27
2025	4	16	13	23	9	0.899	-0.03	3.176	0.016	0.016	0	58.9	60.2	41.3	164	167	0	27	27
2025	4	16	13	33	9	0.938	-0.023	3.173	0.016	0.013	0	59.3	60.2	46	164	167	0	26	27
2025	4	16	13	43	9	0.928	-0.049	3.173	0.013	0.01	0	58.9	59.8	41.7	163	166	0	26	27
2025	4	16	13	53	9	0.922	-0.039	3.173	0.016	0.016	0	58.5	59.8	45.6	163	166	0	27	27
2025	4	16	14	3	9	0.886	-0.033	3.173	0.016	0.013	0	59.3	60.2	63.6	164	167	0	26	27
2025	4	16	14	13	9	0.922	0.01	3.182	0.016	0.013	0	58.9	60.2	39.1	164	167	0	27	27
2025	4	16	14	23	9	0.968	-0.013	3.176	0.016	0.016	0	59.3	60.2	41.3	164	167	0	26	27
2025	4	16	14	33	9	0.906	-0.036	3.176	0.016	0.016	0	58.9	60.2	43	163	166	0	26	26
2025	4	16	14	43	9	0.922	-0.023	3.176	0.013	0.01	0	58.5	60.2	46	163	166	0	27	26
2025	4	16	14	53	9	0.912	-0.049	3.176	0.016	0.016	0	58.9	59.8	62.8	163	166	0	26	27
2025	4	16	15	3	9	0.915	-0.036	3.176	0.016	0.013	0	58.5	60.2	62.4	163	166	0	27	26
2025	4	16	15	13	9	0.925	-0.043	3.176	0.016	0.013	0	58.9	60.2	64.1	164	167	0	27	27
2025	4	16	15	23	9	0.899	-0.03	3.176	0.013	0.01	0	58.9	59.8	64.9	163	166	0	26	27
2025	4	16	15	33	9	0.876	-0.016	3.176	0.016	0.013	0	58.5	60.2	63.6	162	166	0	26	26
2025	4	16	15	43	9	0.915	-0.059	3.176	0.016	0.013	0	58	59.3	62.4	161	165	0	26	27
2025	4	16	15	53	9	0.892	-0.023	3.176	0.016	0.013	0	58.5	59.3	53.3	162	165	0	26	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	16	16	3	9	0.928	-0.007	3.176	0.013	0.01	0	58.5	59.3	46	162	165	0	26	27
2025	4	16	16	13	9	0.919	-0.013	3.176	0.016	0.016	0	58.5	58.5	49	162	163	0	26	27
2025	4	16	16	23	9	0.902	-0.016	3.179	0.013	0.01	0	58.9	59.3	42.1	162	165	0	25	27
2025	4	16	16	33	9	0.935	-0.03	3.176	0.016	0.016	0	58	59.3	58.5	162	165	0	27	27
2025	4	16	16	43	9	0.906	0	3.182	0.016	0.013	0	58.5	59.3	37.8	162	165	0	26	27
2025	4	16	16	53	9	0.938	-0.023	3.176	0.016	0.013	0	58.5	59.3	43.9	162	165	0	26	27
2025	4	16	17	3	9	0.935	-0.026	3.176	0.016	0.013	0	58	59.3	55	161	164	0	26	26
2025	4	16	17	13	9	0.919	-0.016	3.176	0.016	0.016	0	58	59.8	46	162	165	0	27	26
2025	4	16	17	23	9	0.935	-0.016	3.176	0.016	0.013	0	58.5	59.3	45.6	162	165	0	26	27
2025	4	16	17	33	9	0.919	-0.052	3.176	0.013	0.01	0	58	59.3	58.5	162	165	0	27	27
2025	4	16	17	43	9	0.902	-0.033	3.176	0.016	0.016	0	58.5	59.8	48.2	162	165	0	26	26
2025	4	16	17	53	9	0.935	-0.075	3.173	0.013	0.01	0	57.6	58.9	49.5	161	164	0	27	27
2025	4	16	18	3	9	0.932	-0.043	3.176	0.016	0.016	0	58	59.3	55.5	161	165	0	26	27
2025	4	16	18	13	9	0.912	-0.046	3.176	0.016	0.016	0	58	59.3	63.2	162	165	0	27	27
2025	4	16	18	23	9	0.922	-0.066	3.176	0.016	0.013	0	58.5	59.3	61.1	162	165	0	26	27
2025	4	16	18	33	9	0.932	-0.003	3.176	0.02	0.016	0	58.5	59.3	58.9	162	165	0	26	27
2025	4	16	18	43	9	0.892	-0.016	3.179	0.016	0.016	0	58	59.3	44.3	162	165	0	27	27
2025	4	16	18	53	9	0.902	-0.026	3.176	0.016	0.013	0	58.5	59.3	61.1	162	165	0	26	27
2025	4	16	19	3	9	0.909	-0.026	3.176	0.01	0.007	0	58.5	59.8	63.6	162	165	0	26	26
2025	4	16	19	13	9	0.935	-0.059	3.176	0.016	0.013	0	58.5	59.3	63.2	162	165	0	26	27
2025	4	16	19	23	9	0.932	-0.056	3.176	0.013	0.01	0	57.6	58.5	64.1	160	163	0	26	27
2025	4	16	19	33	9	0.909	-0.01	3.176	0.016	0.013	0	57.6	59.3	63.2	161	164	0	27	26
2025	4	16	19	43	9	0.883	-0.036	3.179	0.013	0.01	0	58	58.9	63.2	161	164	0	26	27
2025	4	16	19	53	9	0.951	-0.03	3.179	0.016	0.013	0	57.6	58.9	63.2	160	164	0	26	27
2025	4	16	20	3	9	0.915	-0.039	3.179	0.016	0.013	0	58	58.9	62.4	161	164	0	26	27
2025	4	16	20	13	9	0.925	-0.049	3.179	0.016	0.016	0	57.6	58.9	58	160	163	0	26	26
2025	4	16	20	23	9	0.919	-0.003	3.182	0.013	0.01	0	57.6	58.9	62.8	160	164	0	26	27
2025	4	16	20	33	9	0.922	-0.013	3.179	0.016	0.013	0	57.2	58.9	47.7	160	164	0	27	27
2025	4	16	20	43	9	0.942	-0.049	3.179	0.016	0.013	0	57.6	58.9	47.7	161	164	0	27	27
2025	4	16	20	53	9	0.892	-0.003	3.176	0.016	0.013	0	58	58.9	48.2	161	164	0	26	27
2025	4	16	21	3	9	0.919	-0.026	3.182	0.013	0.01	0	57.6	59.3	63.2	161	164	0	27	26
2025	4	16	21	13	9	0.925	-0.046	3.182	0.016	0.016	0	58	58.5	63.2	161	164	0	26	28
2025	4	16	21	23	9	0.896	-0.026	3.186	0.016	0.013	0	57.6	59.3	63.6	161	164	0	27	26
2025	4	16	21	33	9	0.915	-0.033	3.186	0.013	0.01	0	57.6	58.9	63.6	161	164	0	27	27
2025	4	16	21	43	9	0.909	0.007	3.186	0.016	0.013	0	57.2	58.9	63.6	160	164	0	27	27
2025	4	16	21	53	9	0.919	-0.052	3.186	0.016	0.013	0	58	58.5	63.6	161	163	0	26	27
2025	4	16	22	3	9	0.928	-0.03	3.186	0.02	0.016	0	57.2	58.5	63.2	160	163	0	27	27
2025	4	16	22	13	9	0.919	-0.059	3.186	0.013	0.01	0	57.2	58.9	63.2	160	163	0	27	26
2025	4	16	22	23	9	0.919	-0.003	3.186	0.016	0.013	0	57.2	58.9	63.6	160	164	0	27	27
2025	4	16	22	33	9	0.955	-0.052	3.186	0.016	0.013	0	57.2	58.9	63.6	160	164	0	27	27
2025	4	16	22	43	9	0.883	-0.007	3.186	0.016	0.013	0	58	58.9	63.2	161	164	0	26	27
2025	4	16	22	53	9	0.932	-0.016	3.186	0.016	0.013	0	57.6	58.9	63.6	160	164	0	26	27
2025	4	16	23	3	9	0.922	-0.02	3.186	0.013	0.01	0	57.2	58.9	63.6	160	164	0	27	27
2025	4	16	23	13	9	0.919	-0.023	3.186	0.016	0.013	0	57.6	58.5	63.6	161	164	0	27	28
2025	4	16	23	23	9	0.925	-0.013	3.186	0.016	0.013	0	57.2	59.3	64.1	160	164	0	27	26
2025	4	16	23	33	9	0.899	-0.046	3.186	0.016	0.016	0	58	58.9	64.1	161	164	0	26	27
2025	4	16	23	43	9	0.932	-0.013	3.186	0.013	0.01	0	57.2	58.5	63.6	160	164	0	27	28
2025	4	16	23	53	9	0.938	-0.03	3.186	0.01	0.007	0	57.6	58.9	64.1	161	164	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	17	0	3	9	0.922	-0.059	3.179	0.01	0.007	0	57.2	58.9	50.3	160	164	0	27	27
2025	4	17	0	13	9	0.925	-0.016	3.182	0.016	0.013	0	57.2	58.9	63.2	161	164	0	28	27
2025	4	17	0	23	9	0.922	0.003	3.182	0.016	0.013	0	57.6	58.9	64.1	161	164	0	27	27
2025	4	17	0	33	9	0.912	-0.049	3.182	0.016	0.016	0	57.6	58.9	64.1	160	164	0	26	27
2025	4	17	0	43	9	0.928	-0.049	3.182	0.013	0.01	0	57.2	58.9	63.6	160	164	0	27	27
2025	4	17	0	53	9	0.919	-0.082	3.182	0.016	0.013	0	57.6	58.9	64.1	160	164	0	26	27
2025	4	17	1	3	9	0.919	-0.033	3.182	0.02	0.016	0	57.6	58.5	64.1	160	164	0	26	28
2025	4	17	1	13	9	0.951	-0.056	3.182	0.016	0.013	0	57.6	58.9	63.6	160	164	0	26	27
2025	4	17	1	23	9	0.928	-0.03	3.182	0.01	0.007	0	57.2	59.3	63.6	160	165	0	27	27
2025	4	17	1	33	9	0.883	-0.056	3.182	0.016	0.013	0	57.6	58.9	64.1	161	165	0	27	28
2025	4	17	1	43	9	0.955	-0.039	3.182	0.016	0.016	0	57.6	58.9	63.6	161	164	0	27	27
2025	4	17	1	53	9	0.935	-0.016	3.182	0.016	0.013	0	58	58.9	64.1	161	164	0	26	27
2025	4	17	2	3	9	0.912	-0.033	3.182	0.013	0.01	0	57.6	58.9	64.5	161	164	0	27	27
2025	4	17	2	13	9	0.909	-0.026	3.182	0.02	0.016	0	57.6	59.3	64.1	161	165	0	27	27
2025	4	17	2	23	9	0.942	-0.043	3.182	0.013	0.01	0	57.6	59.3	64.1	161	164	0	27	26
2025	4	17	2	33	9	0.912	-0.043	3.182	0.016	0.016	0	57.6	59.3	64.1	161	165	0	27	27
2025	4	17	2	43	9	0.925	-0.066	3.182	0.016	0.013	0	58	58.9	64.1	161	164	0	26	27
2025	4	17	2	53	9	0.889	-0.03	3.182	0.01	0.007	0	57.6	59.3	64.1	161	165	0	27	27
2025	4	17	3	3	9	0.922	-0.016	3.182	0.016	0.013	0	57.6	58.9	64.1	161	165	0	27	28
2025	4	17	3	13	9	0.909	-0.03	3.182	0.016	0.013	0	57.6	59.8	64.5	161	165	0	27	26
2025	4	17	3	23	9	0.902	-0.049	3.182	0.016	0.016	0	57.6	58.9	64.5	161	164	0	27	27
2025	4	17	3	33	9	0.892	-0.033	3.182	0.016	0.013	0	57.6	59.3	64.5	161	165	0	27	27
2025	4	17	3	43	9	0.912	-0.066	3.182	0.013	0.01	0	57.6	58.9	64.9	161	164	0	27	27
2025	4	17	3	53	9	0.919	-0.023	3.182	0.016	0.013	0	57.6	59.3	63.6	161	165	0	27	27
2025	4	17	4	3	9	0.906	-0.039	3.182	0.016	0.013	0	58	59.3	63.2	161	165	0	26	27
2025	4	17	4	13	9	0.919	-0.033	3.182	0.016	0.013	0	57.6	59.3	64.5	161	165	0	27	27
2025	4	17	4	23	9	0.896	-0.016	3.182	0.016	0.016	0	57.6	59.3	64.5	161	165	0	27	27
2025	4	17	4	33	9	0.892	-0.003	3.179	0.013	0.01	0	57.6	59.3	64.9	161	165	0	27	27
2025	4	17	4	43	9	0.932	0	3.182	0.02	0.016	0	58	59.3	64.1	162	165	0	27	27
2025	4	17	4	53	9	0.932	-0.03	3.182	0.016	0.013	0	57.6	59.3	64.5	161	165	0	27	27
2025	4	17	5	3	9	0.928	-0.016	3.182	0.01	0.007	0	58.5	59.3	64.5	162	165	0	26	27
2025	4	17	5	13	9	0.876	-0.043	3.182	0.016	0.013	0	57.6	59.3	64.9	161	165	0	27	27
2025	4	17	5	23	9	0.932	-0.03	3.179	0.016	0.016	0	58	58.9	64.9	162	165	0	27	28
2025	4	17	5	33	9	0.919	-0.036	3.179	0.013	0.01	0	57.6	59.3	64.5	162	165	0	28	27
2025	4	17	5	43	9	0.906	-0.082	3.179	0.016	0.013	0	58	59.3	64.5	162	165	0	27	27
2025	4	17	5	53	9	0.935	-0.033	3.179	0.016	0.016	0	57.6	59.3	64.9	161	165	0	27	27
2025	4	17	6	3	9	0.902	-0.02	3.182	0.016	0.013	0	57.6	59.3	64.5	161	165	0	27	27
2025	4	17	6	13	9	0.902	-0.03	3.179	0.016	0.013	0	58	59.3	64.5	161	165	0	26	27
2025	4	17	6	23	9	0.902	-0.033	3.179	0.016	0.016	0	58.5	58.9	65.4	162	165	0	26	28
2025	4	17	6	33	9	0.866	-0.036	3.179	0.016	0.013	0	58	58.9	64.5	162	165	0	27	28
2025	4	17	6	43	9	0.906	-0.013	3.179	0.016	0.013	0	57.6	59.3	65.4	162	165	0	28	27
2025	4	17	6	53	9	0.902	-0.036	3.179	0.013	0.01	0	58	59.3	64.1	162	165	0	27	27
2025	4	17	7	3	9	0.892	-0.046	3.179	0.013	0.01	0	58	59.3	64.5	162	165	0	27	27
2025	4	17	7	13	9	0.912	-0.039	3.179	0.016	0.013	0	58	59.3	65.4	161	165	0	26	27
2025	4	17	7	23	9	0.899	-0.016	3.179	0.013	0.01	0	58	58.9	65.4	162	165	0	27	28
2025	4	17	7	33	9	0.889	-0.039	3.179	0.013	0.01	0	58	59.3	65.4	162	165	0	27	27
2025	4	17	7	43	9	0.889	-0.049	3.179	0.016	0.013	0	58	59.8	65.4	162	166	0	27	27
2025	4	17	7	53	9	0.909	-0.059	3.179	0.013	0.01	0	58	58.9	65.4	162	165	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	17	8	3	9	0.906	-0.039	3.179	0.016	0.013	0	57.6	59.8	65.4	162	166	0	28	27
2025	4	17	8	13	9	0.902	-0.036	3.182	0.01	0.007	0	58.5	58.9	65.4	162	165	0	26	28
2025	4	17	8	23	9	0.915	-0.023	3.182	0.013	0.01	0	57.6	59.3	65.8	162	165	0	28	27
2025	4	17	8	33	9	0.928	-0.033	3.179	0.013	0.01	0	58.5	59.3	64.9	163	166	0	27	28
2025	4	17	8	43	9	0.942	-0.02	3.182	0.016	0.016	0	58.5	59.8	65.4	163	166	0	27	27
2025	4	17	8	53	9	0.876	-0.026	3.182	0.016	0.013	0	58.5	59.3	65.8	163	166	0	27	28
2025	4	17	9	3	9	0.912	-0.056	3.182	0.016	0.013	0	58	59.3	64.1	162	166	0	27	28
2025	4	17	9	13	9	0.899	-0.059	3.182	0.013	0.01	0	58.5	59.8	60.6	163	166	0	27	27
2025	4	17	9	23	9	0.896	-0.039	3.182	0.013	0.01	0	57.6	59.8	65.4	162	166	0	28	27
2025	4	17	9	33	9	0.928	-0.049	3.182	0.016	0.013	0	58.5	59.8	64.9	163	166	0	27	27
2025	4	17	9	43	9	0.928	-0.059	3.182	0.016	0.013	0	58.5	59.8	56.8	162	166	0	26	27
2025	4	17	9	53	9	0.892	-0.023	3.182	0.016	0.013	0	58	59.8	57.2	162	166	0	27	27
2025	4	17	10	3	9	0.869	-0.007	3.182	0.016	0.013	0	58	59.8	60.2	162	166	0	27	27
2025	4	17	10	13	9	0.942	-0.036	3.182	0.013	0.01	0	58	59.3	61.1	162	165	0	27	27
2025	4	17	10	23	9	0.938	-0.02	3.182	0.016	0.016	0	58.5	59.8	57.6	162	165	0	26	26
2025	4	17	10	33	9	0.935	-0.043	3.182	0.013	0.01	0	58	58.9	52.5	162	165	0	27	28
2025	4	17	10	43	9	0.915	-0.056	3.182	0.016	0.016	0	57.6	58.9	60.2	162	165	0	28	28
2025	4	17	10	53	9	0.896	-0.026	3.182	0.016	0.013	0	58	59.3	58.9	162	165	0	27	27
2025	4	17	11	3	9	0.925	-0.033	3.182	0.013	0.01	0	58	59.3	62.8	162	165	0	27	27
2025	4	17	11	13	9	0.919	-0.013	3.182	0.013	0.01	0	58	58.9	63.6	162	165	0	27	28
2025	4	17	11	23	9	0.919	-0.049	3.182	0.016	0.013	0	58	59.3	61.5	162	165	0	27	27
2025	4	17	11	33	9	0.906	-0.052	3.182	0.01	0.007	0	58	59.3	58.5	162	165	0	27	27
2025	4	17	11	43	9	0.935	-0.03	3.182	0.013	0.01	0	58	59.3	63.6	162	165	0	27	27
2025	4	17	11	53	9	0.912	-0.026	3.179	0.016	0.013	0	58	59.3	52	162	166	0	27	28
2025	4	17	12	3	9	0.896	0.007	3.179	0.016	0.013	0	58.5	59.3	62.4	162	165	0	26	27
2025	4	17	12	13	9	0.925	-0.023	3.176	0.016	0.013	0	58.5	59.8	55.5	162	165	0	26	26
2025	4	17	12	23	9	0.909	-0.072	3.176	0.016	0.013	0	58	59.3	62.4	162	166	0	27	28
2025	4	17	12	33	9	0.909	-0.03	3.176	0.016	0.013	0	58	59.8	62.4	162	166	0	27	27
2025	4	17	12	43	9	0.932	-0.049	3.176	0.013	0.01	0	58.5	60.2	62.8	163	166	0	27	26
2025	4	17	12	53	9	0.938	-0.023	3.176	0.02	0.016	0	58.9	60.2	61.9	163	167	0	26	27
2025	4	17	13	3	9	0.938	0	3.176	0.016	0.016	0	58.5	59.8	54.6	163	166	0	27	27
2025	4	17	13	13	9	0.932	-0.036	3.179	0.016	0.013	0	58.5	59.8	46.4	163	166	0	27	27
2025	4	17	13	23	9	0.863	0.013	3.179	0.016	0.016	0	58.5	59.8	59.3	163	166	0	27	27
2025	4	17	13	33	9	0.915	-0.003	3.182	0.016	0.013	0	58.5	59.8	41.3	162	166	0	26	27
2025	4	17	13	43	9	0.912	-0.016	3.179	0.016	0.016	0	58.5	59.8	44.7	162	166	0	26	27
2025	4	17	13	53	9	0.909	-0.03	3.182	0.02	0.016	0	58	59.8	46.4	162	166	0	27	27
2025	4	17	14	3	9	0.948	-0.003	3.179	0.016	0.013	0	58.9	59.8	51.2	163	166	0	26	27
2025	4	17	14	13	9	0.951	-0.02	3.179	0.016	0.013	0	58.9	58.5	59.3	163	163	0	26	27
2025	4	17	14	23	9	0.915	-0.026	3.179	0.016	0.013	0	58.5	60.2	49.9	163	167	0	27	27
2025	4	17	14	33	9	0.915	-0.01	3.179	0.016	0.016	0	59.3	60.2	60.6	164	167	0	26	27
2025	4	17	14	43	9	0.945	-0.013	3.186	0.016	0.013	0	58.9	60.2	39.6	163	167	0	26	27
2025	4	17	14	53	9	0.951	-0.056	3.182	0.016	0.013	0	58.5	60.2	39.1	163	166	0	27	26
2025	4	17	15	3	9	0.951	-0.023	3.186	0.02	0.016	0	58.5	60.2	40	162	166	0	26	26
2025	4	17	15	13	9	0.948	-0.016	3.186	0.016	0.016	0	58.9	60.2	39.6	163	167	0	26	27
2025	4	17	15	23	9	0.925	-0.026	3.189	0.016	0.013	0	58.5	60.2	40.4	163	167	0	27	27
2025	4	17	15	33	9	0.899	0.003	3.182	0.016	0.013	0	58.9	60.6	37	163	167	0	26	26
2025	4	17	15	43	9	0.978	-0.046	3.186	0.013	0.01	0	58.9	60.2	40	163	167	0	26	27
2025	4	17	15	53	9	0.968	-0.03	3.189	0.016	0.013	0	58.5	60.2	38.3	163	167	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	17	16	3	9	0.906	-0.036	3.182	0.016	0.016	0	58.5	60.2	37.8	163	166	0	27	26
2025	4	17	16	13	9	0.971	-0.03	3.186	0.016	0.013	0	58.5	59.8	39.6	162	166	0	26	27
2025	4	17	16	23	9	0.896	-0.03	3.189	0.016	0.013	0	58.9	60.2	39.1	163	167	0	26	27
2025	4	17	16	33	9	0.873	-0.036	3.186	0.013	0.01	0	58.5	60.2	40	163	167	0	27	27
2025	4	17	16	43	9	0.948	-0.01	3.189	0.016	0.013	0	58.5	59.8	40	162	166	0	26	27
2025	4	17	16	53	9	0.925	-0.049	3.189	0.016	0.016	0	58.5	59.8	40	163	166	0	27	27
2025	4	17	17	3	9	0.928	-0.056	3.189	0.016	0.016	0	58.5	60.2	35.3	162	166	0	26	26
2025	4	17	17	13	9	0.925	-0.056	3.186	0.016	0.013	0	58	59.8	38.3	161	166	0	26	27
2025	4	17	17	23	9	0.899	-0.026	3.186	0.016	0.013	0	58.5	60.2	39.1	162	166	0	26	26
2025	4	17	17	33	9	0.919	-0.03	3.182	0.016	0.013	0	57.6	59.8	39.1	161	165	0	27	26
2025	4	17	17	43	9	0.906	-0.036	3.186	0.013	0.01	0	58	59.8	40.9	161	165	0	26	26
2025	4	17	17	53	9	0.932	-0.013	3.182	0.016	0.013	0	58	59.3	40	161	165	0	26	27
2025	4	17	18	3	9	0.919	-0.046	3.182	0.016	0.016	0	57.6	59.8	46.4	161	165	0	27	26
2025	4	17	18	13	9	0.942	-0.026	3.182	0.02	0.016	0	58	59.3	62.4	161	165	0	26	27
2025	4	17	18	23	9	0.896	-0.046	3.186	0.016	0.013	0	57.6	59.3	62.4	161	165	0	27	27
2025	4	17	18	33	9	0.925	-0.013	3.186	0.016	0.013	0	58	59.8	61.1	161	165	0	26	26
2025	4	17	18	43	9	0.942	-0.052	3.186	0.016	0.013	0	57.6	59.3	55.5	160	165	0	26	27
2025	4	17	18	53	9	0.919	-0.007	3.186	0.016	0.013	0	57.6	59.3	62.4	161	165	0	27	27
2025	4	17	19	3	9	0.968	-0.003	3.189	0.016	0.013	0	57.6	59.3	62.8	160	165	0	26	27
2025	4	17	19	13	9	0.932	0	3.189	0.016	0.013	0	58	60.2	61.1	161	166	0	26	26
2025	4	17	19	23	9	0.906	-0.039	3.192	0.016	0.013	0	57.6	59.3	62.8	161	165	0	27	27
2025	4	17	19	33	9	0.925	0.003	3.192	0.016	0.013	0	57.6	59.8	61.5	161	165	0	27	26
2025	4	17	19	43	9	0.919	-0.033	3.196	0.013	0.01	0	57.6	59.3	62.8	161	165	0	27	27
2025	4	17	19	53	9	0.932	-0.023	3.196	0.016	0.013	0	57.2	59.3	62.8	160	165	0	27	27
2025	4	17	20	3	9	0.955	-0.016	3.196	0.016	0.013	0	57.2	59.3	61.5	160	165	0	27	27
2025	4	17	20	13	9	0.922	-0.039	3.196	0.016	0.016	0	58	59.3	51.2	161	165	0	26	27
2025	4	17	20	23	9	0.906	-0.059	3.196	0.013	0.01	0	57.6	59.3	48.2	160	165	0	26	27
2025	4	17	20	33	9	0.942	-0.036	3.196	0.016	0.013	0	57.6	59.8	54.6	160	165	0	26	26
2025	4	17	20	43	9	0.919	-0.026	3.196	0.016	0.013	0	57.6	59.8	46.9	161	166	0	27	27
2025	4	17	20	53	9	0.935	-0.043	3.196	0.02	0.016	0	57.2	59.3	46	160	165	0	27	27
2025	4	17	21	3	9	0.909	-0.01	3.196	0.016	0.016	0	57.2	58.9	50.3	160	165	0	27	28
2025	4	17	21	13	9	0.928	-0.046	3.196	0.013	0.01	0	57.2	58.9	46.4	159	164	0	26	27
2025	4	17	21	23	9	0.971	-0.056	3.196	0.016	0.016	0	57.6	58.5	46	160	164	0	26	28
2025	4	17	21	33	9	0.899	-0.016	3.196	0.016	0.013	0	57.6	59.3	58.5	160	165	0	26	27
2025	4	17	21	43	9	0.922	-0.056	3.196	0.01	0.007	0	57.6	58.9	60.2	160	164	0	26	27
2025	4	17	21	53	9	0.892	0.013	3.196	0.016	0.016	0	57.6	59.3	58.9	160	165	0	26	27
2025	4	17	22	3	9	0.932	0	3.196	0.016	0.013	0	57.6	58.9	64.1	160	164	0	26	27
2025	4	17	22	13	9	0.961	-0.016	3.196	0.01	0.007	0	57.2	59.3	64.9	160	165	0	27	27
2025	4	17	22	23	9	0.968	-0.01	3.196	0.016	0.013	0	57.6	59.3	65.8	160	165	0	26	27
2025	4	17	22	33	9	0.899	-0.023	3.196	0.013	0.01	0	57.2	58.9	52.9	160	164	0	27	27
2025	4	17	22	43	9	0.935	-0.01	3.196	0.016	0.013	0	57.6	59.3	65.4	160	165	0	26	27
2025	4	17	22	53	9	0.899	-0.059	3.196	0.013	0.01	0	57.6	59.3	59.3	160	165	0	26	27
2025	4	17	23	3	9	0.948	-0.059	3.192	0.016	0.016	0	57.6	59.3	50.3	160	165	0	26	27
2025	4	17	23	13	9	0.925	-0.033	3.196	0.01	0.007	0	57.2	58.9	63.6	160	164	0	27	27
2025	4	17	23	23	9	0.932	0	3.192	0.016	0.013	0	57.6	59.3	64.9	160	165	0	26	27
2025	4	17	23	33	9	0.915	-0.059	3.192	0.013	0.01	0	57.2	59.3	64.9	160	165	0	27	27
2025	4	17	23	43	9	0.928	-0.007	3.196	0.016	0.016	0	57.6	59.3	65.8	160	165	0	26	27
2025	4	17	23	53	9	0.922	-0.043	3.192	0.016	0.013	0	57.2	58.9	65.8	160	164	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	18	0	3	9	0.912	-0.03	3.192	0.016	0.016	0	57.2	58.9	64.9	160	164	0	27	27
2025	4	18	0	13	9	0.965	-0.036	3.192	0.013	0.01	0	57.6	58.9	66.2	160	164	0	26	27
2025	4	18	0	23	9	0.902	-0.03	3.192	0.013	0.01	0	57.2	58.5	65.8	160	164	0	27	28
2025	4	18	0	33	9	0.912	-0.046	3.192	0.01	0.007	0	57.2	58.9	63.6	160	164	0	27	27
2025	4	18	0	43	9	0.925	-0.023	3.192	0.016	0.013	0	57.2	59.3	66.2	160	165	0	27	27
2025	4	18	0	53	9	0.922	-0.036	3.192	0.016	0.016	0	57.2	58.9	66.7	160	164	0	27	27
2025	4	18	1	3	9	0.925	-0.026	3.192	0.016	0.013	0	57.2	58.9	65.4	159	164	0	26	27
2025	4	18	1	13	9	0.922	-0.043	3.192	0.013	0.01	0	57.2	58.9	60.2	160	164	0	27	27
2025	4	18	1	23	9	0.922	-0.02	3.192	0.013	0.01	0	57.2	58.9	51.6	160	165	0	27	28
2025	4	18	1	33	9	0.991	-0.03	3.192	0.016	0.016	0	57.2	58.9	51.2	160	164	0	27	27
2025	4	18	1	43	9	0.922	-0.016	3.192	0.013	0.01	0	57.2	59.3	62.4	160	165	0	27	27
2025	4	18	1	53	9	0.902	-0.013	3.192	0.013	0.01	0	57.2	58.9	58.5	160	164	0	27	27
2025	4	18	2	3	9	0.906	-0.039	3.192	0.016	0.013	0	57.2	59.3	64.5	160	165	0	27	27
2025	4	18	2	13	9	0.879	0	3.192	0.016	0.016	0	57.2	59.3	64.9	160	165	0	27	27
2025	4	18	2	23	9	0.945	-0.056	3.189	0.013	0.01	0	56.8	58.5	60.6	160	164	0	28	28
2025	4	18	2	33	9	0.938	-0.049	3.192	0.01	0.007	0	57.2	58.9	62.8	160	164	0	27	27
2025	4	18	2	43	9	0.886	-0.039	3.189	0.016	0.013	0	57.2	58.5	47.7	160	164	0	27	28
2025	4	18	2	53	9	0.935	-0.072	3.189	0.016	0.016	0	57.2	58.9	56.8	160	164	0	27	27
2025	4	18	3	3	9	0.932	-0.043	3.189	0.016	0.013	0	57.2	58.9	58.9	160	164	0	27	27
2025	4	18	3	13	9	0.915	-0.033	3.192	0.013	0.01	0	57.2	58.5	42.1	160	164	0	27	28
2025	4	18	3	23	9	0.919	-0.072	3.189	0.016	0.013	0	56.8	58.5	61.5	159	164	0	27	28
2025	4	18	3	33	9	0.928	-0.036	3.189	0.016	0.013	0	57.2	59.3	65.4	160	165	0	27	27
2025	4	18	3	43	9	0.915	-0.02	3.189	0.013	0.01	0	57.2	59.3	64.9	160	165	0	27	27
2025	4	18	3	53	9	0.892	0.003	3.189	0.016	0.013	0	57.2	59.3	63.6	160	165	0	27	27
2025	4	18	4	3	9	0.928	-0.013	3.189	0.013	0.01	0	57.2	59.3	64.9	160	165	0	27	27
2025	4	18	4	13	9	0.896	-0.023	3.189	0.013	0.01	0	57.2	59.3	64.9	160	165	0	27	27
2025	4	18	4	23	9	0.948	-0.043	3.189	0.016	0.013	0	56.8	58.9	65.4	159	164	0	27	27
2025	4	18	4	33	9	0.912	-0.052	3.189	0.016	0.013	0	56.8	58.5	64.9	159	164	0	27	28
2025	4	18	4	43	9	0.899	-0.023	3.189	0.016	0.016	0	57.2	59.3	64.9	160	165	0	27	27
2025	4	18	4	53	9	0.919	-0.052	3.189	0.016	0.013	0	57.2	58.9	64.5	160	165	0	27	28
2025	4	18	5	3	9	0.932	-0.016	3.189	0.016	0.013	0	57.2	59.3	64.1	160	165	0	27	27
2025	4	18	5	13	9	0.928	-0.072	3.189	0.016	0.013	0	57.6	58.9	64.1	160	165	0	26	28
2025	4	18	5	23	9	0.863	-0.016	3.189	0.016	0.013	0	57.2	58.9	64.5	160	165	0	27	28
2025	4	18	5	33	9	0.948	-0.033	3.189	0.01	0.007	0	57.2	59.3	63.6	160	165	0	27	27
2025	4	18	5	43	9	0.902	-0.03	3.189	0.013	0.01	0	57.2	58.9	64.5	160	165	0	27	28
2025	4	18	5	53	9	0.906	-0.049	3.189	0.013	0.01	0	57.2	59.3	63.2	160	165	0	27	27
2025	4	18	6	3	9	0.919	-0.036	3.189	0.016	0.013	0	57.6	59.3	52.5	161	165	0	27	27
2025	4	18	6	13	9	0.915	-0.023	3.189	0.016	0.016	0	57.2	59.3	43.9	161	165	0	28	27
2025	4	18	6	23	9	0.951	-0.043	3.192	0.016	0.013	0	58	58.9	40	162	165	0	27	28
2025	4	18	6	33	9	0.938	-0.046	3.192	0.013	0.01	0	58.5	59.3	40.4	162	165	0	26	27
2025	4	18	6	43	9	0.919	-0.043	3.192	0.013	0.01	0	57.6	58.9	40	162	165	0	28	28
2025	4	18	6	53	9	0.938	-0.052	3.196	0.016	0.013	0	58	59.3	40.9	162	165	0	27	27
2025	4	18	7	3	9	0.909	-0.016	3.192	0.016	0.013	0	58.5	59.8	38.7	163	166	0	27	27
2025	4	18	7	13	9	0.902	-0.036	3.192	0.016	0.016	0	58.5	59.3	38.3	163	166	0	27	28
2025	4	18	7	23	9	0.919	-0.013	3.192	0.016	0.013	0	58.5	59.8	39.6	163	166	0	27	27
2025	4	18	7	33	9	0.919	-0.056	3.192	0.016	0.013	0	58	59.3	40	162	166	0	27	28
2025	4	18	7	43	9	0.915	-0.043	3.196	0.01	0.007	0	58.5	59.3	39.1	163	166	0	27	28
2025	4	18	7	53	9	0.948	-0.03	3.192	0.013	0.01	0	57.6	59.8	40.9	162	166	0	28	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	18	8	3	9	0.925	-0.033	3.196	0.016	0.013	0	58.5	59.3	39.6	163	166	0	27	28
2025	4	18	8	13	9	0.925	0	3.196	0.013	0.01	0	58	59.3	40.4	162	166	0	27	28
2025	4	18	8	23	9	0.922	-0.056	3.192	0.016	0.013	0	58	59.3	40.4	163	166	0	28	28
2025	4	18	8	33	9	0.896	-0.052	3.192	0.013	0.01	0	58.5	59.8	40.9	163	166	0	27	27
2025	4	18	8	43	9	0.919	-0.016	3.192	0.016	0.016	0	58	59.3	40.4	163	166	0	28	28
2025	4	18	8	53	9	0.873	-0.056	3.192	0.016	0.013	0	58.5	59.8	40	163	166	0	27	27
2025	4	18	9	3	9	0.919	-0.023	3.196	0.016	0.013	0	58.5	59.3	39.6	163	166	0	27	28
2025	4	18	9	13	9	0.932	-0.043	3.192	0.013	0.01	0	58	59.8	40	162	166	0	27	27
2025	4	18	9	23	9	0.974	-0.036	3.192	0.013	0.01	0	57.6	58.9	40	162	165	0	28	28
2025	4	18	9	33	9	0.935	-0.043	3.192	0.016	0.013	0	58	59.3	40.4	162	166	0	27	28
2025	4	18	9	43	9	0.942	-0.016	3.196	0.016	0.013	0	58	58.9	41.3	162	165	0	27	28
2025	4	18	9	53	9	0.915	-0.056	3.196	0.016	0.013	0	58	59.3	41.3	162	166	0	27	28
2025	4	18	10	3	9	0.925	-0.059	3.192	0.01	0.007	0	58	59.8	40.4	162	166	0	27	27
2025	4	18	10	13	9	0.925	-0.059	3.196	0.013	0.01	0	57.6	59.8	40.9	162	166	0	28	27
2025	4	18	10	23	9	0.945	0	3.192	0.016	0.013	0	58	58.9	41.7	162	165	0	27	28
2025	4	18	10	33	9	0.935	-0.069	3.192	0.016	0.013	0	58	59.3	41.7	162	166	0	27	28
2025	4	18	10	43	9	0.922	-0.043	3.192	0.016	0.013	0	57.6	59.8	41.3	162	166	0	28	27
2025	4	18	10	53	9	0.935	-0.043	3.196	0.013	0.01	0	57.6	58.9	42.6	162	165	0	28	28
2025	4	18	11	3	9	0.906	-0.085	3.192	0.016	0.016	0	58	58.9	43	162	165	0	27	28
2025	4	18	11	13	9	0.928	-0.02	3.192	0.016	0.013	0	58	58.9	42.1	162	165	0	27	28
2025	4	18	11	23	9	0.945	-0.046	3.192	0.016	0.016	0	58	59.3	42.6	162	165	0	27	27
2025	4	18	11	33	9	0.922	-0.016	3.192	0.016	0.016	0	58	59.3	40.4	162	165	0	27	27
2025	4	18	11	43	9	0.932	0	3.189	0.013	0.01	0	58.5	59.8	41.7	163	166	0	27	27
2025	4	18	11	53	9	0.922	-0.033	3.192	0.016	0.013	0	58.5	59.8	40.9	163	166	0	27	27
2025	4	18	12	3	9	0.951	-0.046	3.192	0.016	0.016	0	58.5	59.3	41.3	163	165	0	27	27
2025	4	18	12	13	9	0.938	-0.03	3.192	0.013	0.01	0	57.6	58.9	42.6	162	165	0	28	28
2025	4	18	12	23	9	0.935	-0.049	3.192	0.016	0.013	0	58	59.3	41.7	162	165	0	27	27
2025	4	18	12	33	9	0.928	-0.033	3.192	0.016	0.016	0	58	59.3	43.9	162	165	0	27	27
2025	4	18	12	43	9	0.958	-0.036	3.192	0.016	0.013	0	58	59.3	43.9	162	165	0	27	27
2025	4	18	12	53	9	0.909	-0.03	3.192	0.016	0.016	0	58.5	59.8	42.6	163	166	0	27	27
2025	4	18	13	3	9	0.958	-0.059	3.192	0.016	0.013	0	58	59.3	43	162	165	0	27	27
2025	4	18	13	13	9	0.938	-0.03	3.192	0.016	0.016	0	58	59.3	57.2	162	165	0	27	27
2025	4	18	13	23	9	0.965	-0.043	3.192	0.016	0.013	0	57.6	59.8	43.4	161	165	0	27	26
2025	4	18	13	33	9	0.902	-0.016	3.196	0.016	0.016	0	58	59.3	41.3	162	166	0	27	28
2025	4	18	13	43	9	0.958	-0.023	3.192	0.016	0.016	0	58.5	59.8	43	163	166	0	27	27
2025	4	18	13	53	9	0.902	-0.013	3.192	0.013	0.01	0	58.5	59.8	43.4	163	166	0	27	27
2025	4	18	14	3	9	0.915	-0.013	3.189	0.016	0.016	0	58.5	59.8	40.9	163	166	0	27	27
2025	4	18	14	13	9	0.965	-0.043	3.192	0.016	0.013	0	58.5	59.8	41.3	162	166	0	26	27
2025	4	18	14	23	9	0.938	-0.02	3.192	0.016	0.016	0	58	59.3	42.6	162	165	0	27	27
2025	4	18	14	33	9	0.981	-0.072	3.192	0.016	0.013	0	58	59.3	41.7	162	165	0	27	27
2025	4	18	14	43	9	0.889	-0.059	3.192	0.013	0.01	0	58.5	59.8	39.1	163	166	0	27	27
2025	4	18	14	53	9	0.922	-0.02	3.192	0.013	0.01	0	58.5	59.8	40.9	163	166	0	27	27
2025	4	18	15	3	9	0.922	-0.003	3.192	0.01	0.007	0	58.5	59.3	40.4	163	166	0	27	28
2025	4	18	15	13	9	0.932	-0.039	3.189	0.016	0.013	0	58.5	59.8	40.4	163	166	0	27	27
2025	4	18	15	23	9	0.919	-0.02	3.189	0.016	0.016	0	58.5	59.8	41.3	163	166	0	27	27
2025	4	18	15	33	9	0.922	-0.016	3.192	0.016	0.013	0	58.5	59.8	41.3	163	166	0	27	27
2025	4	18	15	43	9	0.919	-0.033	3.189	0.013	0.01	0	58.9	59.8	40.4	163	166	0	26	27
2025	4	18	15	53	9	0.951	-0.023	3.189	0.016	0.016	0	58	59.3	42.1	162	165	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	18	16	3	9	0.919	-0.01	3.189	0.013	0.01	0	58.5	59.8	41.7	163	166	0	27	27
2025	4	18	16	13	9	0.958	-0.075	3.192	0.01	0.007	0	58	60.2	43	162	166	0	27	26
2025	4	18	16	23	9	0.919	-0.026	3.192	0.013	0.01	0	58.5	59.8	40	162	166	0	26	27
2025	4	18	16	33	9	0.935	-0.003	3.189	0.013	0.01	0	57.6	59.8	40.9	162	166	0	28	27
2025	4	18	16	43	9	0.928	-0.02	3.189	0.016	0.013	0	58	58.9	40.4	162	165	0	27	28
2025	4	18	16	53	9	0.938	-0.02	3.189	0.016	0.013	0	58	59.8	40	162	166	0	27	27
2025	4	18	17	3	9	0.932	-0.046	3.189	0.016	0.013	0	58	59.3	40.4	162	165	0	27	27
2025	4	18	17	13	9	0.932	0	3.189	0.013	0.01	0	58	58.9	40.4	162	165	0	27	28
2025	4	18	17	23	9	0.919	-0.03	3.189	0.016	0.013	0	57.6	59.3	40.4	161	165	0	27	27
2025	4	18	17	33	9	0.955	-0.003	3.192	0.016	0.013	0	57.6	58.9	40.9	161	164	0	27	27
2025	4	18	17	43	9	0.948	-0.03	3.189	0.016	0.013	0	58	58.9	40.9	161	164	0	26	27
2025	4	18	17	53	9	0.928	-0.03	3.192	0.016	0.013	0	57.6	58.9	41.3	161	164	0	27	27
2025	4	18	18	3	9	0.906	-0.046	3.189	0.013	0.01	0	57.2	58.5	41.7	160	164	0	27	28
2025	4	18	18	13	9	0.922	0	3.192	0.016	0.016	0	57.6	59.3	40.9	161	165	0	27	27
2025	4	18	18	23	9	0.912	-0.046	3.192	0.016	0.013	0	57.6	58.9	40.9	160	164	0	26	27
2025	4	18	18	33	9	0.889	-0.046	3.192	0.016	0.013	0	57.6	59.3	40	161	165	0	27	27
2025	4	18	18	43	9	0.951	-0.059	3.189	0.013	0.01	0	57.2	58.5	42.6	160	164	0	27	28
2025	4	18	18	53	9	0.951	-0.033	3.189	0.016	0.013	0	58	58.9	41.7	161	164	0	26	27
2025	4	18	19	3	9	0.925	-0.01	3.189	0.013	0.01	0	57.6	58.9	43.4	161	164	0	27	27
2025	4	18	19	13	9	0.935	-0.023	3.189	0.013	0.01	0	58	58.9	44.3	161	165	0	26	28
2025	4	18	19	23	9	0.896	-0.033	3.189	0.016	0.013	0	57.2	58.5	42.6	160	164	0	27	28
2025	4	18	19	33	9	0.938	-0.03	3.189	0.013	0.01	0	57.2	58.9	45.2	160	164	0	27	27
2025	4	18	19	43	9	0.932	-0.01	3.189	0.013	0.01	0	57.2	58.5	46	160	164	0	27	28
2025	4	18	19	53	9	0.948	-0.036	3.189	0.013	0.01	0	57.2	58.5	45.6	160	163	0	27	27
2025	4	18	20	3	9	0.915	-0.046	3.189	0.013	0.01	0	57.2	58.5	44.3	160	164	0	27	28
2025	4	18	20	13	9	0.909	-0.026	3.186	0.016	0.013	0	57.2	58.9	55.5	160	164	0	27	27
2025	4	18	20	23	9	0.935	-0.013	3.186	0.016	0.016	0	57.2	58.5	49.9	160	163	0	27	27
2025	4	18	20	33	9	0.971	-0.059	3.186	0.016	0.013	0	56.8	58.5	50.3	159	163	0	27	27
2025	4	18	20	43	9	0.955	-0.023	3.186	0.016	0.016	0	56.8	58.5	49.9	159	163	0	27	27
2025	4	18	20	53	9	0.919	-0.03	3.186	0.01	0.007	0	57.2	58.5	45.6	160	163	0	27	27
2025	4	18	21	3	9	0.932	-0.033	3.186	0.016	0.013	0	57.2	58.5	60.2	160	163	0	27	27
2025	4	18	21	13	9	0.942	-0.026	3.186	0.013	0.01	0	57.2	58.5	62.4	160	163	0	27	27
2025	4	18	21	23	9	0.919	-0.069	3.186	0.016	0.013	0	56.8	58	62.8	159	163	0	27	28
2025	4	18	21	33	9	0.925	-0.03	3.182	0.016	0.013	0	56.8	58.5	57.2	159	163	0	27	27
2025	4	18	21	43	9	0.935	-0.052	3.182	0.016	0.016	0	56.8	58.9	53.3	159	163	0	27	26
2025	4	18	21	53	9	0.912	-0.059	3.182	0.016	0.016	0	56.8	58.5	55.5	159	163	0	27	27
2025	4	18	22	3	9	0.915	-0.033	3.182	0.016	0.016	0	56.8	58.5	51.2	159	163	0	27	27
2025	4	18	22	13	9	0.935	-0.059	3.182	0.01	0.007	0	56.8	58.5	57.6	159	163	0	27	27
2025	4	18	22	23	9	0.928	-0.026	3.182	0.016	0.013	0	56.8	58.5	61.9	159	163	0	27	27
2025	4	18	22	33	9	0.912	-0.036	3.182	0.016	0.013	0	57.6	58	63.2	160	163	0	26	28
2025	4	18	22	43	9	0.919	-0.056	3.182	0.016	0.013	0	56.8	58	61.9	159	163	0	27	28
2025	4	18	22	53	9	0.938	-0.036	3.182	0.016	0.013	0	57.2	58	65.8	160	163	0	27	28
2025	4	18	23	3	9	0.915	-0.052	3.182	0.016	0.013	0	56.8	58	64.9	159	163	0	27	28
2025	4	18	23	13	9	0.915	-0.043	3.182	0.016	0.013	0	56.8	58	64.5	160	163	0	28	28
2025	4	18	23	23	9	0.925	-0.039	3.182	0.016	0.016	0	56.8	58	63.6	159	163	0	27	28
2025	4	18	23	33	9	0.889	-0.046	3.182	0.01	0.007	0	56.8	57.6	61.9	159	162	0	27	28
2025	4	18	23	43	9	0.932	-0.052	3.182	0.016	0.013	0	56.3	57.6	54.2	159	162	0	28	28
2025	4	18	23	53	9	0.942	-0.043	3.179	0.016	0.013	0	56.3	58	58	159	162	0	28	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	19	0	3	9	0.909	-0.049	3.182	0.016	0.013	0	56.8	57.6	65.8	159	162	0	27	28
2025	4	19	0	13	9	0.955	-0.033	3.182	0.016	0.016	0	56.3	57.2	64.5	158	162	0	27	29
2025	4	19	0	23	9	0.912	-0.059	3.182	0.013	0.01	0	56.3	57.6	65.8	158	162	0	27	28
2025	4	19	0	33	9	0.925	-0.033	3.179	0.016	0.013	0	55.9	57.6	64.9	158	162	0	28	28
2025	4	19	0	43	9	0.922	-0.03	3.182	0.016	0.013	0	56.8	58	64.9	159	162	0	27	27
2025	4	19	0	53	9	0.902	-0.056	3.179	0.016	0.016	0	55.9	58	64.9	158	162	0	28	27
2025	4	19	1	3	9	0.909	-0.052	3.179	0.016	0.013	0	57.2	57.6	64.5	159	162	0	26	28
2025	4	19	1	13	9	0.892	-0.03	3.179	0.01	0.007	0	56.3	58	63.6	158	162	0	27	27
2025	4	19	1	23	9	0.938	-0.049	3.179	0.016	0.013	0	55.9	57.6	63.6	158	161	0	28	27
2025	4	19	1	33	9	0.906	-0.056	3.179	0.016	0.013	0	56.3	57.6	63.6	158	162	0	27	28
2025	4	19	1	43	9	0.925	-0.069	3.179	0.016	0.013	0	56.3	57.2	64.1	158	161	0	27	28
2025	4	19	1	53	9	0.915	-0.052	3.179	0.013	0.01	0	56.3	57.2	63.2	158	161	0	27	28
2025	4	19	2	3	9	0.945	-0.013	3.179	0.013	0.01	0	56.3	58	63.2	158	162	0	27	27
2025	4	19	2	13	9	0.915	-0.03	3.179	0.016	0.016	0	56.3	57.6	63.2	158	161	0	27	27
2025	4	19	2	23	9	0.955	-0.056	3.182	0.016	0.013	0	56.3	57.2	64.1	158	161	0	27	28
2025	4	19	2	33	9	0.945	-0.056	3.182	0.01	0.007	0	56.3	57.6	63.2	158	161	0	27	27
2025	4	19	2	43	9	0.922	-0.049	3.182	0.016	0.013	0	55.9	57.2	63.6	158	161	0	28	28
2025	4	19	2	53	9	0.942	-0.069	3.182	0.016	0.013	0	56.3	57.2	64.5	158	161	0	27	28
2025	4	19	3	3	9	0.883	-0.049	3.186	0.016	0.013	0	55.9	57.6	62.8	158	161	0	28	27
2025	4	19	3	13	9	0.906	-0.066	3.186	0.016	0.013	0	55.5	57.2	63.6	157	161	0	28	28
2025	4	19	3	23	9	0.919	-0.062	3.186	0.016	0.013	0	55.5	57.2	64.1	157	161	0	28	28
2025	4	19	3	33	9	0.892	-0.043	3.189	0.016	0.013	0	55.5	57.2	64.1	157	161	0	28	28
2025	4	19	3	43	9	0.899	-0.039	3.189	0.016	0.013	0	55.9	57.2	64.1	157	161	0	27	28
2025	4	19	3	53	9	0.925	-0.059	3.189	0.016	0.013	0	55.5	57.2	64.5	157	161	0	28	28
2025	4	19	4	3	9	0.899	-0.016	3.192	0.016	0.016	0	55.5	57.2	64.1	157	161	0	28	28
2025	4	19	4	13	9	0.919	-0.046	3.192	0.016	0.013	0	55.9	57.2	64.5	157	161	0	27	28
2025	4	19	4	23	9	0.919	-0.013	3.192	0.016	0.013	0	55.9	57.2	64.1	157	161	0	27	28
2025	4	19	4	33	9	0.909	-0.059	3.192	0.02	0.016	0	55.5	57.2	64.5	157	161	0	28	28
2025	4	19	4	43	9	0.935	-0.039	3.192	0.02	0.016	0	55.5	57.2	64.5	157	161	0	28	28
2025	4	19	4	53	9	0.919	-0.03	3.192	0.013	0.01	0	56.3	57.2	64.1	158	161	0	27	28
2025	4	19	5	3	9	0.928	-0.052	3.192	0.016	0.013	0	55.9	57.2	64.9	157	161	0	27	28
2025	4	19	5	13	9	0.948	-0.062	3.192	0.013	0.01	0	55.9	57.2	64.5	157	161	0	27	28
2025	4	19	5	23	9	0.906	-0.062	3.192	0.016	0.013	0	55.9	57.2	64.1	157	161	0	27	28
2025	4	19	5	33	9	0.928	-0.02	3.192	0.016	0.013	0	56.3	57.2	63.6	158	161	0	27	28
2025	4	19	5	43	9	0.906	-0.013	3.192	0.016	0.016	0	55.9	57.2	63.6	157	161	0	27	28
2025	4	19	5	53	9	0.906	-0.03	3.192	0.016	0.013	0	55.5	57.2	65.8	157	161	0	28	28
2025	4	19	6	3	9	0.899	-0.043	3.192	0.013	0.01	0	55.9	57.2	66.7	158	161	0	28	28
2025	4	19	6	13	9	0.902	-0.02	3.192	0.013	0.01	0	55.9	57.2	66.7	157	161	0	27	28
2025	4	19	6	23	9	0.896	-0.043	3.192	0.016	0.016	0	55.9	57.6	63.2	158	162	0	28	28
2025	4	19	6	33	9	0.915	-0.066	3.192	0.016	0.013	0	55.9	56.8	66.2	157	160	0	27	28
2025	4	19	6	43	9	0.958	-0.016	3.192	0.01	0.007	0	55.9	56.8	67.1	157	160	0	27	28
2025	4	19	6	53	9	0.932	-0.003	3.192	0.016	0.013	0	56.3	57.2	61.1	158	161	0	27	28
2025	4	19	7	3	9	0.932	-0.039	3.192	0.016	0.013	0	55.9	56.8	65.4	157	160	0	27	28
2025	4	19	7	13	9	0.922	0.01	3.192	0.013	0.01	0	55.9	57.2	66.2	158	161	0	28	28
2025	4	19	7	23	9	0.945	-0.056	3.192	0.016	0.013	0	55.9	56.8	64.1	157	160	0	27	28
2025	4	19	7	33	9	0.942	-0.033	3.192	0.013	0.01	0	55.9	56.8	67.5	157	160	0	27	28
2025	4	19	7	43	9	0.902	-0.062	3.192	0.016	0.016	0	55.9	56.8	60.6	157	160	0	27	28
2025	4	19	7	53	9	0.925	-0.095	3.192	0.016	0.013	0	55.5	56.3	62.8	156	159	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	19	8	3	9	0.906	-0.046	3.189	0.013	0.01	0	55.5	56.3	55	157	160	0	28	29
2025	4	19	8	13	9	0.935	-0.056	3.192	0.016	0.013	0	55	55.9	66.7	156	159	0	28	29
2025	4	19	8	23	9	0.968	-0.059	3.192	0.016	0.013	0	55.5	56.8	66.7	156	159	0	27	27
2025	4	19	8	33	9	0.928	-0.062	3.192	0.013	0.01	0	55.5	56.8	65.8	157	160	0	28	28
2025	4	19	8	43	9	0.922	-0.046	3.189	0.016	0.013	0	55	56.3	50.7	156	159	0	28	28
2025	4	19	8	53	9	0.928	-0.056	3.192	0.016	0.013	0	55	57.2	63.6	156	160	0	28	27
2025	4	19	9	3	9	0.935	-0.036	3.192	0.013	0.01	0	55	56.8	65.4	156	160	0	28	28
2025	4	19	9	13	9	0.906	-0.033	3.192	0.016	0.013	0	55	56.8	64.9	156	160	0	28	28
2025	4	19	9	23	9	0.925	-0.046	3.192	0.016	0.013	0	55.5	56.8	64.5	156	160	0	27	28
2025	4	19	9	33	9	0.942	-0.059	3.189	0.013	0.01	0	55.5	56.8	48.2	156	160	0	27	28
2025	4	19	9	43	9	0.938	-0.023	3.192	0.01	0.007	0	55.5	56.8	64.1	156	160	0	27	28
2025	4	19	9	53	9	0.935	-0.046	3.189	0.016	0.013	0	55.5	56.3	48.6	156	159	0	27	28
2025	4	19	10	3	9	0.915	-0.033	3.192	0.016	0.013	0	55.5	57.2	64.9	156	160	0	27	27
2025	4	19	10	13	9	0.912	-0.043	3.189	0.01	0.007	0	55	57.2	64.1	156	160	0	28	27
2025	4	19	10	23	9	0.925	-0.043	3.186	0.016	0.013	0	55.5	55.5	63.2	157	157	0	28	28
2025	4	19	10	33	9	0.883	-0.069	3.186	0.016	0.013	0	55.9	57.6	64.5	157	161	0	27	27
2025	4	19	10	43	9	0.938	-0.059	3.186	0.016	0.013	0	55	56.3	65.4	156	159	0	28	28
2025	4	19	10	53	9	0.955	-0.03	3.182	0.01	0.007	0	55	56.8	64.1	156	160	0	28	28
2025	4	19	11	3	9	0.886	-0.059	3.182	0.016	0.016	0	55.5	56.8	64.5	156	160	0	27	28
2025	4	19	11	13	9	0.896	-0.039	3.182	0.016	0.013	0	55.9	56.8	66.2	157	160	0	27	28
2025	4	19	11	23	9	0.899	-0.069	3.182	0.016	0.013	0	55	57.2	66.2	156	160	0	28	27
2025	4	19	11	33	9	0.902	-0.023	3.182	0.016	0.013	0	55.5	57.2	65.4	156	160	0	27	27
2025	4	19	11	43	9	0.919	-0.082	3.186	0.016	0.013	0	55	56.8	64.5	156	160	0	28	28
2025	4	19	11	53	9	0.961	-0.043	3.186	0.013	0.01	0	55	56.8	66.7	156	160	0	28	28
2025	4	19	12	3	9	0.912	-0.036	3.186	0.013	0.01	0	55.9	56.8	67.1	157	160	0	27	28
2025	4	19	12	13	9	0.925	-0.016	3.186	0.016	0.016	0	55	56.8	67.1	156	160	0	28	28
2025	4	19	12	23	9	0.922	-0.046	3.182	0.016	0.013	0	55.9	57.6	46.4	157	161	0	27	27
2025	4	19	12	33	9	0.951	-0.052	3.186	0.013	0.01	0	55.9	57.2	67.9	157	160	0	27	27
2025	4	19	12	43	9	0.925	-0.049	3.186	0.016	0.013	0	55.9	57.2	49.5	157	160	0	27	27
2025	4	19	12	53	9	0.958	-0.016	3.186	0.016	0.013	0	55.9	56.8	66.7	157	160	0	27	28
2025	4	19	13	3	9	0.951	-0.059	3.186	0.016	0.013	0	55.9	56.8	43	157	160	0	27	28
2025	4	19	13	13	9	0.886	-0.023	3.186	0.016	0.013	0	55.9	57.6	61.5	157	161	0	27	27
2025	4	19	13	23	9	0.942	-0.079	3.186	0.016	0.013	0	55.9	57.2	42.1	157	161	0	27	28
2025	4	19	13	33	9	0.915	-0.036	3.186	0.016	0.016	0	56.3	57.6	46.9	158	161	0	27	27
2025	4	19	13	43	9	0.928	-0.023	3.186	0.013	0.01	0	55.9	57.2	41.7	157	161	0	27	28
2025	4	19	13	53	9	0.935	-0.023	3.186	0.013	0.01	0	56.3	57.6	43	158	161	0	27	27
2025	4	19	14	3	9	0.906	-0.046	3.186	0.013	0.01	0	56.8	57.6	43	158	161	0	26	27
2025	4	19	14	13	9	0.906	-0.043	3.189	0.013	0.01	0	56.8	57.6	43.9	159	162	0	27	28
2025	4	19	14	23	9	0.945	-0.059	3.189	0.01	0.007	0	56.3	57.6	42.6	158	161	0	27	27
2025	4	19	14	33	9	0.909	-0.049	3.186	0.016	0.013	0	56.8	58	42.6	159	162	0	27	27
2025	4	19	14	43	9	0.938	-0.043	3.186	0.016	0.013	0	56.3	57.6	40.9	158	162	0	27	28
2025	4	19	14	53	9	0.912	-0.046	3.189	0.016	0.013	0	56.8	58	45.6	159	162	0	27	27
2025	4	19	15	3	9	0.932	-0.036	3.189	0.016	0.013	0	56.8	57.6	42.1	158	161	0	26	27
2025	4	19	15	13	9	0.965	-0.052	3.189	0.013	0.01	0	56.8	58	43	159	162	0	27	27
2025	4	19	15	23	9	0.942	-0.016	3.186	0.016	0.016	0	56.8	57.6	41.7	159	162	0	27	28
2025	4	19	15	33	9	0.915	-0.046	3.186	0.016	0.013	0	56.8	58	42.6	159	162	0	27	27
2025	4	19	15	43	9	0.928	-0.039	3.189	0.013	0.01	0	56.8	58	42.1	159	162	0	27	27
2025	4	19	15	53	9	0.928	-0.059	3.189	0.016	0.016	0	56.8	58	40.4	159	162	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	19	16	3	9	0.945	-0.052	3.186	0.016	0.013	0	57.2	58.5	41.7	159	163	0	26	27
2025	4	19	16	13	9	0.925	-0.046	3.189	0.016	0.016	0	56.8	58.5	41.7	159	163	0	27	27
2025	4	19	16	23	9	0.932	-0.03	3.182	0.016	0.013	0	57.2	58	41.3	160	163	0	27	28
2025	4	19	16	33	9	0.968	-0.033	3.186	0.016	0.016	0	56.8	58	40.9	159	162	0	27	27
2025	4	19	16	43	9	0.922	-0.043	3.189	0.016	0.013	0	57.2	58	40.9	159	163	0	26	28
2025	4	19	16	53	9	0.912	-0.052	3.182	0.016	0.013	0	56.8	58.9	38.7	159	163	0	27	26
2025	4	19	17	3	9	0.932	-0.02	3.186	0.016	0.013	0	56.8	58	40.4	159	162	0	27	27
2025	4	19	17	13	9	0.925	-0.049	3.186	0.016	0.013	0	56.3	58	40.9	158	162	0	27	27
2025	4	19	17	23	9	0.958	-0.059	3.186	0.016	0.013	0	57.2	58	40	159	162	0	26	27
2025	4	19	17	33	9	0.945	-0.056	3.186	0.016	0.013	0	56.3	58	42.1	158	162	0	27	27
2025	4	19	17	43	9	0.906	-0.069	3.189	0.016	0.016	0	57.2	58	39.1	159	162	0	26	27
2025	4	19	17	53	9	0.922	-0.046	3.186	0.016	0.016	0	57.2	58	43.4	159	162	0	26	27
2025	4	19	18	3	9	0.938	-0.036	3.186	0.013	0.01	0	57.2	58	40	159	162	0	26	27
2025	4	19	18	13	9	0.945	-0.056	3.186	0.016	0.013	0	55.9	58	40	157	162	0	27	27
2025	4	19	18	23	9	0.886	-0.033	3.189	0.013	0.01	0	57.2	57.6	56.3	159	162	0	26	28
2025	4	19	18	33	9	0.906	-0.062	3.189	0.013	0.01	0	56.8	58	67.1	159	162	0	27	27
2025	4	19	18	43	9	0.951	-0.033	3.189	0.013	0.01	0	56.3	58	67.1	158	162	0	27	27
2025	4	19	18	53	9	0.942	-0.036	3.189	0.016	0.013	0	56.8	57.6	64.5	159	162	0	27	28
2025	4	19	19	3	9	0.912	-0.03	3.189	0.016	0.016	0	57.2	58	48.6	159	163	0	26	28
2025	4	19	19	13	9	0.922	-0.059	3.186	0.013	0.01	0	56.3	58.5	44.7	159	163	0	28	27
2025	4	19	19	23	9	0.919	-0.039	3.186	0.013	0.01	0	57.2	58.5	40.4	159	163	0	26	27
2025	4	19	19	33	9	0.935	-0.066	3.186	0.016	0.013	0	56.8	58.5	41.7	159	163	0	27	27
2025	4	19	19	43	9	0.928	-0.03	3.189	0.01	0.007	0	56.8	55.9	57.2	159	157	0	27	27
2025	4	19	19	53	9	0.922	-0.01	3.189	0.013	0.01	0	57.2	58	66.7	160	163	0	27	28
2025	4	19	20	3	9	0.912	-0.016	3.189	0.016	0.013	0	57.2	58.5	66.7	160	163	0	27	27
2025	4	19	20	13	9	0.892	-0.03	3.189	0.016	0.013	0	57.2	58.5	66.7	160	163	0	27	27
2025	4	19	20	23	9	0.951	-0.013	3.189	0.016	0.013	0	57.2	58.5	66.7	160	163	0	27	27
2025	4	19	20	33	9	0.906	-0.03	3.189	0.013	0.01	0	57.6	58	67.1	160	163	0	26	28
2025	4	19	20	43	9	0.909	-0.013	3.189	0.016	0.013	0	57.2	58.5	67.1	160	163	0	27	27
2025	4	19	20	53	9	0.896	-0.056	3.189	0.016	0.013	0	57.2	58.5	67.1	160	163	0	27	27
2025	4	19	21	3	9	0.935	-0.043	3.186	0.016	0.013	0	57.2	58.5	67.1	160	163	0	27	27
2025	4	19	21	13	9	0.948	-0.069	3.186	0.013	0.01	0	57.2	57.6	67.1	160	162	0	27	28
2025	4	19	21	23	9	0.919	-0.043	3.186	0.013	0.01	0	57.2	58	67.1	160	163	0	27	28
2025	4	19	21	33	9	0.922	-0.016	3.186	0.013	0.01	0	57.2	57.6	67.1	160	162	0	27	28
2025	4	19	21	43	9	0.902	-0.033	3.186	0.016	0.016	0	57.2	58.5	67.1	160	163	0	27	27
2025	4	19	21	53	9	0.915	-0.036	3.186	0.016	0.016	0	57.2	58	67.5	160	162	0	27	27
2025	4	19	22	3	9	0.886	-0.059	3.186	0.016	0.013	0	57.2	58	67.1	160	163	0	27	28
2025	4	19	22	13	9	0.932	-0.03	3.186	0.016	0.013	0	57.2	58.5	67.5	160	163	0	27	27
2025	4	19	22	23	9	0.919	-0.052	3.186	0.01	0.007	0	57.2	58.5	67.9	160	163	0	27	27
2025	4	19	22	33	9	0.925	-0.043	3.186	0.016	0.013	0	57.2	58	67.5	160	163	0	27	28
2025	4	19	22	43	9	0.889	-0.039	3.186	0.016	0.013	0	57.2	58.5	67.5	160	163	0	27	27
2025	4	19	22	53	9	0.922	-0.049	3.182	0.013	0.01	0	56.8	58	67.9	159	163	0	27	28
2025	4	19	23	3	9	0.915	0	3.182	0.016	0.013	0	56.8	58	67.1	159	162	0	27	27
2025	4	19	23	13	9	0.922	-0.039	3.182	0.016	0.013	0	56.8	58	66.7	159	162	0	27	27
2025	4	19	23	23	9	0.955	-0.02	3.182	0.016	0.013	0	56.8	58	67.5	159	162	0	27	27
2025	4	19	23	33	9	0.915	-0.023	3.182	0.016	0.013	0	57.2	58	67.1	160	163	0	27	28
2025	4	19	23	43	9	0.912	-0.01	3.182	0.013	0.01	0	56.8	57.6	66.7	159	162	0	27	28
2025	4	19	23	53	9	0.886	-0.043	3.182	0.016	0.013	0	56.8	58	66.7	160	163	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	20	0	3	9	0.942	-0.033	3.182	0.016	0.013	0	56.8	58	67.1	159	162	0	27	27
2025	4	20	0	13	9	0.889	-0.023	3.182	0.016	0.013	0	56.8	58	67.1	159	162	0	27	27
2025	4	20	0	23	9	0.965	-0.049	3.182	0.016	0.013	0	57.2	58	67.1	159	162	0	26	27
2025	4	20	0	33	9	0.906	-0.03	3.179	0.013	0.01	0	56.8	58.5	67.5	159	162	0	27	26
2025	4	20	0	43	9	0.915	-0.066	3.179	0.013	0.01	0	56.8	57.6	67.5	159	162	0	27	28
2025	4	20	0	53	9	0.915	-0.007	3.179	0.013	0.01	0	56.8	58.5	67.1	159	163	0	27	27
2025	4	20	1	3	9	0.892	-0.016	3.179	0.016	0.013	0	57.2	58.5	66.7	160	163	0	27	27
2025	4	20	1	13	9	0.892	-0.03	3.179	0.016	0.016	0	56.3	57.6	67.1	159	162	0	28	28
2025	4	20	1	23	9	0.915	-0.056	3.179	0.013	0.01	0	56.8	57.6	67.5	159	162	0	27	28
2025	4	20	1	33	9	0.889	-0.023	3.179	0.016	0.013	0	56.8	58	66.7	159	162	0	27	27
2025	4	20	1	43	9	0.899	-0.023	3.179	0.013	0.01	0	56.8	58	67.5	159	162	0	27	27
2025	4	20	1	53	9	0.919	-0.039	3.179	0.013	0.01	0	56.8	57.6	67.1	159	162	0	27	28
2025	4	20	2	3	9	0.925	-0.03	3.179	0.016	0.016	0	56.8	57.6	67.5	159	162	0	27	28
2025	4	20	2	13	9	0.932	-0.03	3.179	0.016	0.013	0	56.8	58	67.1	159	162	0	27	27
2025	4	20	2	23	9	0.922	-0.043	3.179	0.016	0.013	0	56.8	57.6	67.1	159	162	0	27	28
2025	4	20	2	33	9	0.909	-0.043	3.179	0.013	0.01	0	56.8	58	67.1	159	162	0	27	27
2025	4	20	2	43	9	0.899	-0.023	3.176	0.016	0.013	0	56.3	57.6	66.7	159	162	0	28	28
2025	4	20	2	53	9	0.932	-0.02	3.176	0.01	0.007	0	56.8	58	67.1	159	162	0	27	27
2025	4	20	3	3	9	0.883	-0.056	3.176	0.016	0.013	0	56.3	57.6	66.7	159	162	0	28	28
2025	4	20	3	13	9	0.899	-0.043	3.176	0.016	0.016	0	56.3	58	67.1	159	162	0	28	27
2025	4	20	3	23	9	0.932	-0.026	3.176	0.016	0.013	0	56.8	57.6	67.1	159	162	0	27	28
2025	4	20	3	33	9	0.928	-0.043	3.176	0.02	0.016	0	56.8	57.6	67.1	159	162	0	27	28
2025	4	20	3	43	9	0.928	-0.03	3.176	0.016	0.013	0	56.8	57.6	67.1	159	162	0	27	28
2025	4	20	3	53	9	0.925	-0.036	3.176	0.01	0.007	0	56.8	58	66.2	159	163	0	27	28
2025	4	20	4	3	9	0.922	-0.026	3.176	0.013	0.01	0	56.3	57.6	66.2	159	162	0	28	28
2025	4	20	4	13	9	0.919	-0.03	3.176	0.01	0.007	0	56.8	58.5	66.7	159	163	0	27	27
2025	4	20	4	23	9	0.925	-0.072	3.176	0.016	0.013	0	56.3	58	66.2	159	163	0	28	28
2025	4	20	4	33	9	0.915	-0.043	3.176	0.016	0.016	0	56.8	58	66.2	159	163	0	27	28
2025	4	20	4	43	9	0.925	-0.026	3.176	0.016	0.013	0	57.2	58	66.2	160	163	0	27	28
2025	4	20	4	53	9	0.909	-0.036	3.176	0.016	0.013	0	56.3	58	66.7	159	163	0	28	28
2025	4	20	5	3	9	0.948	-0.046	3.176	0.016	0.016	0	56.8	58	66.2	159	163	0	27	28
2025	4	20	5	13	9	0.906	-0.03	3.176	0.016	0.013	0	56.3	58	65.8	159	163	0	28	28
2025	4	20	5	23	9	0.919	-0.03	3.176	0.016	0.013	0	56.8	58.5	66.2	159	163	0	27	27
2025	4	20	5	33	9	0.919	-0.046	3.176	0.013	0.01	0	56.8	58	66.2	159	163	0	27	28
2025	4	20	5	43	9	0.919	-0.01	3.176	0.016	0.013	0	56.8	57.6	65.4	159	162	0	27	28
2025	4	20	5	53	9	0.919	-0.03	3.176	0.016	0.016	0	56.8	57.6	65.8	159	162	0	27	28
2025	4	20	6	3	9	0.889	-0.03	3.176	0.01	0.007	0	56.3	58	65.8	159	162	0	28	27
2025	4	20	6	13	9	0.938	-0.03	3.176	0.013	0.01	0	56.3	58.5	65.4	159	163	0	28	27
2025	4	20	6	23	9	0.922	-0.043	3.176	0.016	0.013	0	57.2	58	65.8	160	163	0	27	28
2025	4	20	6	33	9	0.938	-0.066	3.176	0.016	0.016	0	56.8	58	65.4	160	163	0	28	28
2025	4	20	6	43	9	0.899	-0.026	3.176	0.016	0.013	0	57.2	58	64.9	160	163	0	27	28
2025	4	20	6	53	9	0.915	-0.043	3.176	0.016	0.013	0	56.8	58	65.4	159	163	0	27	28
2025	4	20	7	3	9	0.932	-0.013	3.176	0.016	0.013	0	57.2	58	65.4	160	163	0	27	28
2025	4	20	7	13	9	0.935	-0.039	3.176	0.013	0.01	0	56.8	58	65.4	159	163	0	27	28
2025	4	20	7	23	9	0.915	-0.046	3.176	0.01	0.007	0	56.8	58	65.4	159	163	0	27	28
2025	4	20	7	33	9	0.915	-0.072	3.176	0.016	0.016	0	56.8	58.5	65.4	159	163	0	27	27
2025	4	20	7	43	9	0.935	-0.033	3.176	0.016	0.013	0	56.8	57.6	65.4	159	162	0	27	28
2025	4	20	7	53	9	0.919	-0.026	3.176	0.016	0.013	0	56.8	58.5	65.8	159	163	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	20	8	3	9	0.951	-0.01	3.176	0.016	0.016	0	56.3	58	65.8	159	163	0	28	28
2025	4	20	8	13	9	0.902	-0.049	3.176	0.016	0.016	0	56.3	58	65.4	159	163	0	28	28
2025	4	20	8	23	9	0.896	-0.075	3.176	0.016	0.013	0	56.8	58	65.8	159	163	0	27	28
2025	4	20	8	33	9	0.915	-0.036	3.176	0.016	0.013	0	56.8	57.6	66.2	159	162	0	27	28
2025	4	20	8	43	9	0.938	-0.043	3.179	0.01	0.007	0	56.8	58	65.8	159	163	0	27	28
2025	4	20	8	53	9	0.899	-0.02	3.179	0.016	0.013	0	56.3	58	65.8	159	163	0	28	28
2025	4	20	9	3	9	0.945	-0.059	3.179	0.016	0.016	0	55.9	58	66.7	158	162	0	28	27
2025	4	20	9	13	9	0.915	-0.043	3.179	0.016	0.013	0	56.3	58	66.2	159	162	0	28	27
2025	4	20	9	23	9	0.945	-0.049	3.179	0.016	0.016	0	56.3	58	66.7	159	162	0	28	27
2025	4	20	9	33	9	0.925	-0.036	3.179	0.013	0.01	0	55.9	57.6	65.8	158	162	0	28	28
2025	4	20	9	43	9	0.909	-0.056	3.179	0.016	0.013	0	56.8	57.6	65.8	159	162	0	27	28
2025	4	20	9	53	9	0.925	-0.066	3.179	0.02	0.016	0	56.8	58	56.3	159	162	0	27	27
2025	4	20	10	3	9	0.886	-0.056	3.179	0.016	0.013	0	56.8	58.5	66.7	159	163	0	27	27
2025	4	20	10	13	9	0.886	-0.043	3.179	0.01	0.007	0	56.3	58	65.4	159	163	0	28	28
2025	4	20	10	23	9	0.919	-0.013	3.182	0.016	0.013	0	56.8	57.6	66.7	159	162	0	27	28
2025	4	20	10	33	9	0.935	-0.049	3.182	0.013	0.01	0	56.8	58	66.7	159	163	0	27	28
2025	4	20	10	43	9	0.925	-0.049	3.182	0.016	0.013	0	56.8	58	53.3	159	162	0	27	27
2025	4	20	10	53	9	0.906	-0.039	3.182	0.01	0.007	0	56.8	58.5	66.7	159	163	0	27	27
2025	4	20	11	3	9	0.879	-0.026	3.182	0.013	0.01	0	56.3	58	65.8	159	163	0	28	28
2025	4	20	11	13	9	0.955	-0.023	3.182	0.016	0.016	0	56.8	58	44.7	159	163	0	27	28
2025	4	20	11	23	9	0.896	-0.016	3.186	0.016	0.013	0	56.8	58.5	48.2	159	163	0	27	27
2025	4	20	11	33	9	0.899	-0.016	3.186	0.016	0.016	0	57.2	58.5	41.7	160	164	0	27	28
2025	4	20	11	43	9	0.915	-0.043	3.186	0.016	0.013	0	56.8	58.5	47.3	159	163	0	27	27
2025	4	20	11	53	9	0.912	-0.03	3.186	0.016	0.013	0	56.8	58.5	41.7	159	163	0	27	27
2025	4	20	12	3	9	0.945	-0.016	3.186	0.016	0.013	0	56.8	58.5	43.4	159	163	0	27	27
2025	4	20	12	13	9	0.948	-0.082	3.186	0.016	0.013	0	57.2	58	42.1	159	163	0	26	28
2025	4	20	12	23	9	0.935	-0.023	3.186	0.013	0.01	0	56.8	58.5	39.1	159	163	0	27	27
2025	4	20	12	33	9	0.912	-0.059	3.189	0.016	0.013	0	56.8	58	43	159	163	0	27	28
2025	4	20	12	43	9	0.925	-0.039	3.182	0.016	0.013	0	56.8	58.5	41.3	159	163	0	27	27
2025	4	20	12	53	9	0.932	-0.043	3.186	0.016	0.013	0	56.3	58	40.9	159	163	0	28	28
2025	4	20	13	3	9	0.906	-0.052	3.182	0.016	0.013	0	56.8	58.5	41.7	159	163	0	27	27
2025	4	20	13	13	9	0.942	-0.059	3.186	0.013	0.01	0	57.2	58.9	41.3	160	164	0	27	27
2025	4	20	13	23	9	0.932	-0.03	3.182	0.016	0.013	0	57.2	58.9	39.1	160	164	0	27	27
2025	4	20	13	33	9	0.915	-0.046	3.186	0.013	0.01	0	57.2	58.9	40.9	160	164	0	27	27
2025	4	20	13	43	9	0.948	-0.049	3.189	0.016	0.013	0	57.2	58.5	40.9	160	163	0	27	27
2025	4	20	13	53	9	0.919	-0.033	3.189	0.016	0.013	0	57.2	58.9	40.4	160	164	0	27	27
2025	4	20	14	3	9	0.951	-0.023	3.186	0.016	0.013	0	57.2	58.5	37.8	160	163	0	27	27
2025	4	20	14	13	9	0.925	-0.046	3.182	0.016	0.013	0	57.2	58.9	40.9	160	164	0	27	27
2025	4	20	14	23	9	0.928	-0.03	3.186	0.016	0.013	0	57.2	58.9	40.4	160	164	0	27	27
2025	4	20	14	33	9	0.948	-0.043	3.192	0.016	0.013	0	57.2	58.9	41.3	160	164	0	27	27
2025	4	20	14	43	9	0.928	-0.026	3.186	0.016	0.013	0	57.6	58.5	40.9	161	164	0	27	28
2025	4	20	14	53	9	0.932	-0.023	3.189	0.013	0.01	0	57.6	58.9	38.3	161	164	0	27	27
2025	4	20	15	3	9	0.925	-0.03	3.186	0.013	0.01	0	58	58.9	38.7	161	164	0	26	27
2025	4	20	15	13	9	0.942	-0.01	3.186	0.016	0.013	0	57.6	58.9	41.7	161	164	0	27	27
2025	4	20	15	23	9	0.935	-0.052	3.192	0.016	0.013	0	58	59.3	41.7	161	164	0	26	26
2025	4	20	15	33	9	0.951	-0.003	3.189	0.013	0.01	0	58	58.9	37.8	161	164	0	26	27
2025	4	20	15	43	9	0.948	-0.016	3.186	0.013	0.01	0	58	59.3	39.6	162	165	0	27	27
2025	4	20	15	53	9	0.951	-0.036	3.192	0.016	0.013	0	58	59.3	40.9	161	165	0	26	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	20	16	3	9	0.958	-0.039	3.192	0.016	0.016	0	57.6	58.9	41.3	161	164	0	27	27
2025	4	20	16	13	9	0.955	-0.03	3.192	0.016	0.013	0	58	58.9	40.9	162	165	0	27	28
2025	4	20	16	23	9	0.925	-0.02	3.186	0.016	0.013	0	58	59.3	42.1	162	165	0	27	27
2025	4	20	16	33	9	0.968	-0.062	3.186	0.016	0.016	0	58	59.3	40.9	162	165	0	27	27
2025	4	20	16	43	9	0.955	-0.043	3.189	0.016	0.016	0	58	59.8	40	162	165	0	27	26
2025	4	20	16	53	9	0.912	-0.049	3.186	0.016	0.013	0	58	59.3	37.4	162	166	0	27	28
2025	4	20	17	3	9	0.922	-0.039	3.189	0.016	0.013	0	57.6	59.3	40	161	165	0	27	27
2025	4	20	17	13	9	0.932	0	3.189	0.013	0.01	0	58	59.3	39.1	161	165	0	26	27
2025	4	20	17	23	9	0.958	-0.033	3.189	0.016	0.016	0	57.6	59.3	36.5	160	164	0	26	26
2025	4	20	17	33	9	0.965	-0.072	3.189	0.016	0.016	0	57.6	59.3	36.5	161	165	0	27	27
2025	4	20	17	43	9	0.948	-0.023	3.189	0.016	0.016	0	57.6	59.3	37.8	161	165	0	27	27
2025	4	20	17	53	9	0.938	-0.049	3.192	0.016	0.013	0	57.2	58.5	40.4	160	164	0	27	28
2025	4	20	18	3	9	0.928	-0.013	3.192	0.013	0.01	0	58	58.9	40.9	161	164	0	26	27
2025	4	20	18	13	9	0.935	-0.013	3.192	0.013	0.01	0	57.2	58.9	41.3	160	163	0	27	26
2025	4	20	18	23	9	0.932	-0.023	3.192	0.016	0.013	0	57.6	58.9	46	160	164	0	26	27
2025	4	20	18	33	9	0.925	-0.003	3.192	0.016	0.013	0	57.6	58.9	40.9	160	164	0	26	27
2025	4	20	18	43	9	0.945	-0.069	3.192	0.01	0.007	0	57.2	58.9	43.9	160	164	0	27	27
2025	4	20	18	53	9	0.971	-0.01	3.192	0.013	0.01	0	57.2	58.5	42.6	160	163	0	27	27
2025	4	20	19	3	9	0.883	-0.046	3.192	0.016	0.016	0	58	58.9	42.1	161	164	0	26	27
2025	4	20	19	13	9	0.919	-0.03	3.192	0.013	0.01	0	57.2	58.9	40.9	160	164	0	27	27
2025	4	20	19	23	9	0.942	0	3.196	0.016	0.013	0	57.6	59.3	40	160	164	0	26	26
2025	4	20	19	33	9	0.955	-0.023	3.192	0.016	0.013	0	57.2	59.3	40	160	164	0	27	26
2025	4	20	19	43	9	0.928	-0.02	3.192	0.013	0.01	0	57.2	58.9	41.7	160	164	0	27	27
2025	4	20	19	53	9	0.945	-0.036	3.192	0.013	0.01	0	57.2	58.9	41.7	160	164	0	27	27
2025	4	20	20	3	9	0.951	-0.026	3.192	0.016	0.013	0	57.2	58.9	43	160	164	0	27	27
2025	4	20	20	13	9	0.938	-0.026	3.196	0.016	0.013	0	57.6	58.5	56.8	160	163	0	26	27
2025	4	20	20	23	9	0.945	-0.016	3.192	0.016	0.016	0	57.2	58.9	43	160	164	0	27	27
2025	4	20	20	33	9	0.886	-0.02	3.196	0.016	0.013	0	57.6	58.9	65.4	161	164	0	27	27
2025	4	20	20	43	9	0.938	-0.036	3.196	0.016	0.013	0	57.2	56.8	65.8	160	160	0	27	28
2025	4	20	20	53	9	0.919	-0.016	3.196	0.016	0.013	0	57.6	58.5	66.2	160	164	0	26	28
2025	4	20	21	3	9	0.948	-0.023	3.196	0.016	0.016	0	57.2	58.9	66.2	160	164	0	27	27
2025	4	20	21	13	9	0.906	-0.046	3.196	0.016	0.013	0	57.2	58.9	62.8	160	164	0	27	27
2025	4	20	21	23	9	0.938	-0.026	3.196	0.016	0.013	0	57.2	58.9	66.7	160	164	0	27	27
2025	4	20	21	33	9	0.928	-0.01	3.196	0.016	0.013	0	57.2	58.9	66.7	160	164	0	27	27
2025	4	20	21	43	9	0.958	-0.056	3.196	0.013	0.01	0	57.6	58.9	66.7	160	164	0	26	27
2025	4	20	21	53	9	0.906	-0.01	3.196	0.016	0.016	0	57.2	58.9	66.2	160	164	0	27	27
2025	4	20	22	3	9	0.955	-0.02	3.196	0.016	0.013	0	57.2	58.9	67.1	160	164	0	27	27
2025	4	20	22	13	9	0.948	-0.03	3.192	0.016	0.013	0	57.6	58.9	66.7	160	164	0	26	27
2025	4	20	22	23	9	0.942	-0.013	3.192	0.016	0.016	0	57.2	58.9	66.2	160	164	0	27	27
2025	4	20	22	33	9	0.915	-0.046	3.192	0.016	0.013	0	57.2	59.3	67.1	160	164	0	27	26
2025	4	20	22	43	9	0.958	-0.02	3.192	0.016	0.013	0	57.2	58.9	66.7	160	164	0	27	27
2025	4	20	22	53	9	0.928	-0.03	3.192	0.013	0.01	0	57.6	58.9	66.7	160	164	0	26	27
2025	4	20	23	3	9	0.958	-0.033	3.192	0.016	0.013	0	56.8	58.5	67.1	159	163	0	27	27
2025	4	20	23	13	9	0.958	0	3.192	0.016	0.013	0	57.2	58.9	67.1	160	164	0	27	27
2025	4	20	23	23	9	0.932	-0.072	3.192	0.013	0.01	0	57.2	58	66.7	159	163	0	26	28
2025	4	20	23	33	9	0.928	-0.007	3.192	0.016	0.016	0	56.8	58.5	66.7	159	163	0	27	27
2025	4	20	23	43	9	0.919	0	3.192	0.016	0.013	0	57.6	58.9	66.2	160	164	0	26	27
2025	4	20	23	53	9	0.899	-0.079	3.192	0.013	0.01	0	57.2	58	66.7	159	163	0	26	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	21	0	3	9	0.889	-0.03	3.192	0.016	0.013	0	56.8	58.5	66.2	159	163	0	27	27
2025	4	21	0	13	9	0.942	-0.003	3.192	0.013	0.01	0	57.2	58.9	66.7	160	164	0	27	27
2025	4	21	0	23	9	0.938	-0.046	3.192	0.016	0.013	0	57.2	58.9	65.8	160	164	0	27	27
2025	4	21	0	33	9	0.925	-0.026	3.189	0.016	0.016	0	57.6	58.9	66.2	161	164	0	27	27
2025	4	21	0	43	9	0.899	-0.03	3.189	0.016	0.016	0	57.2	58.5	66.7	160	163	0	27	27
2025	4	21	0	53	9	0.906	-0.016	3.189	0.016	0.013	0	57.2	58.5	65.8	161	164	0	28	28
2025	4	21	1	3	9	0.919	0	3.189	0.013	0.01	0	57.2	58.9	66.2	160	164	0	27	27
2025	4	21	1	13	9	0.915	0.013	3.189	0.016	0.013	0	57.6	58.9	66.2	161	164	0	27	27
2025	4	21	1	23	9	0.902	-0.03	3.189	0.016	0.013	0	57.2	58.5	65.8	160	164	0	27	28
2025	4	21	1	33	9	0.922	-0.039	3.189	0.016	0.016	0	57.2	58.5	67.1	160	163	0	27	27
2025	4	21	1	43	9	0.951	-0.052	3.189	0.016	0.013	0	57.2	58.5	66.2	160	163	0	27	27
2025	4	21	1	53	9	0.948	-0.049	3.189	0.016	0.013	0	57.2	58.5	66.2	160	163	0	27	27
2025	4	21	2	3	9	0.945	-0.02	3.189	0.013	0.01	0	57.2	58	66.7	159	163	0	26	28
2025	4	21	2	13	9	0.938	-0.056	3.189	0.016	0.016	0	57.2	58.5	65.8	160	163	0	27	27
2025	4	21	2	23	9	0.955	-0.016	3.189	0.02	0.016	0	56.3	58	66.2	159	163	0	28	28
2025	4	21	2	33	9	0.935	-0.043	3.189	0.013	0.01	0	56.8	58.9	65.8	159	164	0	27	27
2025	4	21	2	43	9	0.935	-0.01	3.189	0.016	0.016	0	57.2	58.9	65.8	160	164	0	27	27
2025	4	21	2	53	9	0.886	-0.043	3.189	0.016	0.013	0	57.6	58	66.2	160	163	0	26	28
2025	4	21	3	3	9	0.938	-0.033	3.189	0.02	0.016	0	57.2	58.5	66.2	160	163	0	27	27
2025	4	21	3	13	9	0.928	-0.013	3.189	0.016	0.013	0	57.2	58.5	65.8	160	163	0	27	27
2025	4	21	3	23	9	0.912	-0.026	3.189	0.016	0.013	0	57.2	58.9	65.8	160	164	0	27	27
2025	4	21	3	33	9	0.925	-0.023	3.189	0.016	0.013	0	57.2	58	66.7	160	163	0	27	28
2025	4	21	3	43	9	0.909	-0.03	3.186	0.016	0.016	0	57.2	58.9	66.2	160	164	0	27	27
2025	4	21	3	53	9	0.906	-0.016	3.186	0.016	0.016	0	57.2	58.5	65.8	160	163	0	27	27
2025	4	21	4	3	9	0.942	-0.033	3.186	0.016	0.016	0	57.2	58.5	65.8	160	164	0	27	28
2025	4	21	4	13	9	0.968	-0.033	3.186	0.013	0.01	0	56.3	58.9	66.2	159	163	0	28	26
2025	4	21	4	23	9	0.942	-0.007	3.186	0.01	0.007	0	57.2	58.5	65.4	160	163	0	27	27
2025	4	21	4	33	9	0.925	-0.043	3.186	0.016	0.013	0	56.8	58.5	66.2	160	163	0	28	27
2025	4	21	4	43	9	0.919	-0.003	3.186	0.013	0.01	0	57.2	58.5	66.2	160	163	0	27	27
2025	4	21	4	53	9	0.942	-0.03	3.186	0.016	0.016	0	57.2	58.9	65.4	160	164	0	27	27
2025	4	21	5	3	9	0.915	-0.03	3.186	0.02	0.016	0	57.6	58.9	64.9	161	165	0	27	28
2025	4	21	5	13	9	0.925	0	3.186	0.013	0.01	0	56.8	58.9	65.8	160	164	0	28	27
2025	4	21	5	23	9	0.915	-0.043	3.186	0.013	0.01	0	57.2	58.9	65.4	160	164	0	27	27
2025	4	21	5	33	9	0.955	-0.003	3.186	0.016	0.013	0	57.2	58.9	65.4	160	164	0	27	27
2025	4	21	5	43	9	0.935	-0.046	3.186	0.016	0.016	0	56.8	58.9	65.8	160	164	0	28	27
2025	4	21	5	53	9	0.873	-0.033	3.186	0.013	0.01	0	57.2	58.5	64.9	160	164	0	27	28
2025	4	21	6	3	9	0.909	-0.01	3.186	0.016	0.013	0	56.8	58.9	64.9	160	164	0	28	27
2025	4	21	6	13	9	0.942	-0.043	3.186	0.013	0.01	0	57.2	58.5	65.8	160	164	0	27	28
2025	4	21	6	23	9	0.928	-0.046	3.186	0.013	0.01	0	57.2	58.5	65.8	160	164	0	27	28
2025	4	21	6	33	9	0.912	0.003	3.186	0.016	0.016	0	57.6	58.9	64.5	161	165	0	27	28
2025	4	21	6	43	9	0.915	-0.03	3.186	0.013	0.01	0	58	58.9	64.9	161	165	0	26	28
2025	4	21	6	53	9	0.912	-0.026	3.186	0.016	0.013	0	57.6	59.3	65.4	161	165	0	27	27
2025	4	21	7	3	9	0.915	-0.062	3.186	0.013	0.01	0	57.2	58.5	65.4	160	164	0	27	28
2025	4	21	7	13	9	0.935	-0.016	3.186	0.013	0.01	0	57.2	58	65.4	160	163	0	27	28
2025	4	21	7	23	9	0.968	-0.033	3.186	0.016	0.013	0	57.2	58.9	64.9	160	164	0	27	27
2025	4	21	7	33	9	0.928	-0.02	3.186	0.016	0.013	0	57.2	58.9	64.9	161	164	0	28	27
2025	4	21	7	43	9	0.935	-0.039	3.186	0.01	0.007	0	57.2	59.3	65.8	160	164	0	27	26
2025	4	21	7	53	9	0.919	-0.052	3.186	0.013	0.01	0	57.6	58.9	64.5	161	164	0	27	27

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	4	21	8	3	9	0.896	-0.026	3.186	0.016	0.016	0	57.6	58.9	57.6	161	164	0	27	27
2025	4	21	8	13	9	0.935	-0.02	3.186	0.016	0.013	0	57.6	58.5	45.2	161	164	0	27	28
2025	4	21	9	55	46	28.2	-0.7	0.972	0.4	0.3	0	58	58.9	0	161	164	0	26	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	1	0	3	9	28	0	0	0	0	0	0	0	51.91	0	0
2025	4	1	0	13	9	27	0	0	0	0	0	0	0	51.82	0	0
2025	4	1	0	23	9	27	0	0	0	0	0	0	0	51.76	0	0
2025	4	1	0	33	9	28	0	0	0	0	0	0	0	51.69	0	0
2025	4	1	0	43	9	27	0	0	0	0	0	0	0	51.6	0	0
2025	4	1	0	53	9	27	0	0	0	0	0	0	0	51.53	0	0
2025	4	1	1	3	9	27	0	0	0	0	0	0	0	51.46	0	0
2025	4	1	1	13	9	27	0	0	0	0	0	0	0	51.39	0	0
2025	4	1	1	23	9	28	0	0	0	0	0	0	0	51.31	0	0
2025	4	1	1	33	9	27	0	0	0	0	0	0	0	51.26	0	0
2025	4	1	1	43	9	27	0	0	0	0	0	0	0	51.21	0	0
2025	4	1	1	53	9	27	0	0	0	0	0	0	0	51.15	0	0
2025	4	1	2	3	9	27	0	0	0	0	0	0	0	51.08	0	0
2025	4	1	2	13	9	27	0	0	0	0	0	0	0	51.03	0	0
2025	4	1	2	23	9	27	0	0	0	0	0	0	0	50.97	0	0
2025	4	1	2	33	9	27	0	0	0	0	0	0	0	50.94	0	0
2025	4	1	2	43	9	27	0	0	0	0	0	0	0	50.88	0	0
2025	4	1	2	53	9	27	0	0	0	0	0	0	0	50.81	0	0
2025	4	1	3	3	9	27	0	0	0	0	0	0	0	50.76	0	0
2025	4	1	3	13	9	27	0	0	0	0	0	0	0	50.7	0	0
2025	4	1	3	23	9	27	0	0	0	0	0	0	0	50.61	0	0
2025	4	1	3	33	9	28	0	0	0	0	0	0	0	50.56	0	0
2025	4	1	3	43	9	27	0	0	0	0	0	0	0	50.49	0	0
2025	4	1	3	53	9	27	0	0	0	0	0	0	0	50.4	0	0
2025	4	1	4	3	9	27	0	0	0	0	0	0	0	50.32	0	0
2025	4	1	4	13	9	27	0	0	0	0	0	0	0	50.25	0	0
2025	4	1	4	23	9	27	0	0	0	0	0	0	0	50.18	0	0
2025	4	1	4	33	9	27	0	0	0	0	0	0	0	50.11	0	0
2025	4	1	4	43	9	27	0	0	0	0	0	0	0	50.05	0	0
2025	4	1	4	53	9	27	0	0	0	0	0	0	0	49.98	0	0
2025	4	1	5	3	9	27	0	0	0	0	0	0	0	49.93	0	0
2025	4	1	5	13	9	28	0	0	0	0	0	0	0	49.84	0	0
2025	4	1	5	23	9	28	0	0	0	0	0	0	0	49.78	0	0
2025	4	1	5	33	9	27	0	0	0	0	0	0	0	49.69	0	0
2025	4	1	5	43	9	27	0	0	0	0	0	0	0	49.64	0	0
2025	4	1	5	53	9	27	0	0	0	0	0	0	0	49.57	0	0
2025	4	1	6	3	9	27	0	0	0	0	0	0	0	49.5	0	0
2025	4	1	6	13	9	28	0	0	0	0	0	0	0	49.42	0	0
2025	4	1	6	23	9	27	0	0	0	0	0	0	0	49.35	0	0
2025	4	1	6	33	9	28	0	0	0	0	0	0	0	49.3	0	0
2025	4	1	6	43	9	27	0	0	0	0	0	0	0	49.23	0	0
2025	4	1	6	53	9	28	0	0	0	0	0	0	0	49.15	0	0
2025	4	1	7	3	9	28	0	0	0	0	0	0	0	49.12	0	0
2025	4	1	7	13	9	27	0	0	0	0	0	0	0	49.08	0	0
2025	4	1	7	23	9	28	0	0	0	0	0	0	0	49.06	0	0
2025	4	1	7	33	9	28	0	0	0	0	0	0	0	49.05	0	0
2025	4	1	7	43	9	27	0	0	0	0	0	0	0	49.05	0	0
2025	4	1	7	53	9	28	0	0	0	0	0	0	0	49.06	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	1	8	3	9	27	0	0	0	0	0	0	0	49.08	0	0
2025	4	1	8	13	9	27	0	0	0	0	0	0	0	49.1	0	0
2025	4	1	8	23	9	28	0	0	0	0	0	0	0	49.15	0	0
2025	4	1	8	33	9	27	0	0	0	0	0	0	0	49.21	0	0
2025	4	1	8	43	9	28	0	0	0	0	0	0	0	49.28	0	0
2025	4	1	8	53	9	28	0	0	0	0	0	0	0	49.37	0	0
2025	4	1	9	3	9	28	0	0	0	0	0	0	0	49.46	0	0
2025	4	1	9	13	9	28	0	0	0	0	0	0	0	49.59	0	0
2025	4	1	9	23	9	27	0	0	0	0	0	0	0	49.69	0	0
2025	4	1	9	33	9	28	0	0	0	0	0	0	0	49.84	0	0
2025	4	1	9	43	9	27	0	0	0	0	0	0	0	49.96	0	0
2025	4	1	9	53	9	28	0	0	0	0	0	0	0	50.13	0	0
2025	4	1	10	3	9	28	0	0	0	0	0	0	0	50.29	0	0
2025	4	1	10	13	9	28	0	0	0	0	0	0	0	50.45	0	0
2025	4	1	10	23	9	27	0	0	0	0	0	0	0	50.65	0	0
2025	4	1	10	33	9	28	0	0	0	0	0	0	0	50.83	0	0
2025	4	1	10	43	9	28	0	0	0	0	0	0	0	51.01	0	0
2025	4	1	10	53	9	27	0	0	0	0	0	0	0	51.19	0	0
2025	4	1	11	3	9	28	0	0	0	0	0	0	0	51.35	0	0
2025	4	1	11	13	9	27	0	0	0	0	0	0	0	51.57	0	0
2025	4	1	11	23	9	28	0	0	0	0	0	0	0	51.75	0	0
2025	4	1	11	33	9	28	0	0	0	0	0	0	0	51.87	0	0
2025	4	1	11	43	9	27	0	0	0	0	0	0	0	52	0	0
2025	4	1	11	53	9	28	0	0	0	0	0	0	0	52.12	0	0
2025	4	1	12	3	9	27	0	0	0	0	0	0	0	52.23	0	0
2025	4	1	12	13	9	28	0	0	0	0	0	0	0	52.34	0	0
2025	4	1	12	23	9	27	0	0	0	0	0	0	0	52.48	0	0
2025	4	1	12	33	9	28	0	0	0	0	0	0	0	52.68	0	0
2025	4	1	12	43	9	27	0	0	0	0	0	0	0	52.92	0	0
2025	4	1	12	53	9	28	0	0	0	0	0	0	0	53.06	0	0
2025	4	1	13	3	9	27	0	0	0	0	0	0	0	53.13	0	0
2025	4	1	13	13	9	27	0	0	0	0	0	0	0	53.19	0	0
2025	4	1	13	23	9	27	0	0	0	0	0	0	0	53.24	0	0
2025	4	1	13	33	9	27	0	0	0	0	0	0	0	53.28	0	0
2025	4	1	13	43	9	27	0	0	0	0	0	0	0	53.33	0	0
2025	4	1	13	53	9	27	0	0	0	0	0	0	0	53.42	0	0
2025	4	1	14	3	9	27	0	0	0	0	0	0	0	53.49	0	0
2025	4	1	14	13	9	27	0	0	0	0	0	0	0	53.58	0	0
2025	4	1	14	23	9	27	0	0	0	0	0	0	0	53.64	0	0
2025	4	1	14	33	9	27	0	0	0	0	0	0	0	53.69	0	0
2025	4	1	14	43	9	27	0	0	0	0	0	0	0	53.8	0	0
2025	4	1	14	53	9	26	0	0	0	0	0	0	0	53.91	0	0
2025	4	1	15	3	9	27	0	0	0	0	0	0	0	54.01	0	0
2025	4	1	15	13	9	27	0	0	0	0	0	0	0	54.1	0	0
2025	4	1	15	23	9	27	0	0	0	0	0	0	0	54.19	0	0
2025	4	1	15	33	9	27	0	0	0	0	0	0	0	54.28	0	0
2025	4	1	15	43	9	27	0	0	0	0	0	0	0	54.34	0	0
2025	4	1	15	53	9	27	0	0	0	0	0	0	0	54.39	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	1	16	3	9	27	0	0	0	0	0	0	0	54.45	0	0
2025	4	1	16	13	9	27	0	0	0	0	0	0	0	54.5	0	0
2025	4	1	16	23	9	27	0	0	0	0	0	0	0	54.54	0	0
2025	4	1	16	33	9	26	0	0	0	0	0	0	0	54.57	0	0
2025	4	1	16	43	9	27	0	0	0	0	0	0	0	54.59	0	0
2025	4	1	16	53	9	27	0	0	0	0	0	0	0	54.59	0	0
2025	4	1	17	3	9	27	0	0	0	0	0	0	0	54.59	0	0
2025	4	1	17	13	9	28	0	0	0	0	0	0	0	54.57	0	0
2025	4	1	17	23	9	27	0	0	0	0	0	0	0	54.55	0	0
2025	4	1	17	33	9	27	0	0	0	0	0	0	0	54.48	0	0
2025	4	1	17	43	9	27	0	0	0	0	0	0	0	54.43	0	0
2025	4	1	17	53	9	28	0	0	0	0	0	0	0	54.36	0	0
2025	4	1	18	3	9	27	0	0	0	0	0	0	0	54.25	0	0
2025	4	1	18	13	9	28	0	0	0	0	0	0	0	54.14	0	0
2025	4	1	18	23	9	26	0	0	0	0	0	0	0	54.01	0	0
2025	4	1	18	33	9	27	0	0	0	0	0	0	0	53.89	0	0
2025	4	1	18	43	9	27	0	0	0	0	0	0	0	53.76	0	0
2025	4	1	18	53	9	27	0	0	0	0	0	0	0	53.64	0	0
2025	4	1	19	3	9	28	0	0	0	0	0	0	0	53.51	0	0
2025	4	1	19	13	9	27	0	0	0	0	0	0	0	53.38	0	0
2025	4	1	19	23	9	27	0	0	0	0	0	0	0	53.28	0	0
2025	4	1	19	33	9	28	0	0	0	0	0	0	0	53.17	0	0
2025	4	1	19	43	9	27	0	0	0	0	0	0	0	53.08	0	0
2025	4	1	19	53	9	27	0	0	0	0	0	0	0	52.99	0	0
2025	4	1	20	3	9	28	0	0	0	0	0	0	0	52.92	0	0
2025	4	1	20	13	9	27	0	0	0	0	0	0	0	52.83	0	0
2025	4	1	20	23	9	27	0	0	0	0	0	0	0	52.75	0	0
2025	4	1	20	33	9	27	0	0	0	0	0	0	0	52.65	0	0
2025	4	1	20	43	9	26	0	0	0	0	0	0	0	52.57	0	0
2025	4	1	20	53	9	27	0	0	0	0	0	0	0	52.47	0	0
2025	4	1	21	3	9	27	0	0	0	0	0	0	0	52.39	0	0
2025	4	1	21	13	9	27	0	0	0	0	0	0	0	52.3	0	0
2025	4	1	21	23	9	27	0	0	0	0	0	0	0	52.23	0	0
2025	4	1	21	33	9	27	0	0	0	0	0	0	0	52.14	0	0
2025	4	1	21	43	9	27	0	0	0	0	0	0	0	52.05	0	0
2025	4	1	21	53	9	28	0	0	0	0	0	0	0	51.98	0	0
2025	4	1	22	3	9	28	0	0	0	0	0	0	0	51.91	0	0
2025	4	1	22	13	9	27	0	0	0	0	0	0	0	51.84	0	0
2025	4	1	22	23	9	27	0	0	0	0	0	0	0	51.78	0	0
2025	4	1	22	33	9	28	0	0	0	0	0	0	0	51.69	0	0
2025	4	1	22	43	9	27	0	0	0	0	0	0	0	51.6	0	0
2025	4	1	22	53	9	28	0	0	0	0	0	0	0	51.51	0	0
2025	4	1	23	3	9	27	0	0	0	0	0	0	0	51.44	0	0
2025	4	1	23	13	9	27	0	0	0	0	0	0	0	51.35	0	0
2025	4	1	23	23	9	28	0	0	0	0	0	0	0	51.24	0	0
2025	4	1	23	33	9	28	0	0	0	0	0	0	0	51.17	0	0
2025	4	1	23	43	9	28	0	0	0	0	0	0	0	51.06	0	0
2025	4	1	23	53	9	27	0	0	0	0	0	0	0	50.97	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	2	0	3	9	27	0	0	0	0	0	0	0	50.86	0	0
2025	4	2	0	13	9	27	0	0	0	0	0	0	0	50.79	0	0
2025	4	2	0	23	9	27	0	0	0	0	0	0	0	50.68	0	0
2025	4	2	0	33	9	27	0	0	0	0	0	0	0	50.59	0	0
2025	4	2	0	43	9	28	0	0	0	0	0	0	0	50.49	0	0
2025	4	2	0	53	9	27	0	0	0	0	0	0	0	50.41	0	0
2025	4	2	1	3	9	27	0	0	0	0	0	0	0	50.31	0	0
2025	4	2	1	13	9	28	0	0	0	0	0	0	0	50.23	0	0
2025	4	2	1	23	9	28	0	0	0	0	0	0	0	50.13	0	0
2025	4	2	1	33	9	27	0	0	0	0	0	0	0	50.04	0	0
2025	4	2	1	43	9	28	0	0	0	0	0	0	0	49.95	0	0
2025	4	2	1	53	9	27	0	0	0	0	0	0	0	49.86	0	0
2025	4	2	2	3	9	28	0	0	0	0	0	0	0	49.77	0	0
2025	4	2	2	13	9	28	0	0	0	0	0	0	0	49.71	0	0
2025	4	2	2	23	9	28	0	0	0	0	0	0	0	49.62	0	0
2025	4	2	2	33	9	27	0	0	0	0	0	0	0	49.53	0	0
2025	4	2	2	43	9	27	0	0	0	0	0	0	0	49.44	0	0
2025	4	2	2	53	9	27	0	0	0	0	0	0	0	49.37	0	0
2025	4	2	3	3	9	28	0	0	0	0	0	0	0	49.28	0	0
2025	4	2	3	13	9	28	0	0	0	0	0	0	0	49.21	0	0
2025	4	2	3	23	9	28	0	0	0	0	0	0	0	49.12	0	0
2025	4	2	3	33	9	27	0	0	0	0	0	0	0	49.05	0	0
2025	4	2	3	43	9	27	0	0	0	0	0	0	0	48.96	0	0
2025	4	2	3	53	9	28	0	0	0	0	0	0	0	48.88	0	0
2025	4	2	4	3	9	28	0	0	0	0	0	0	0	48.79	0	0
2025	4	2	4	13	9	28	0	0	0	0	0	0	0	48.7	0	0
2025	4	2	4	23	9	28	0	0	0	0	0	0	0	48.61	0	0
2025	4	2	4	33	9	27	0	0	0	0	0	0	0	48.52	0	0
2025	4	2	4	43	9	28	0	0	0	0	0	0	0	48.45	0	0
2025	4	2	4	53	9	28	0	0	0	0	0	0	0	48.38	0	0
2025	4	2	5	3	9	27	0	0	0	0	0	0	0	48.29	0	0
2025	4	2	5	13	9	28	0	0	0	0	0	0	0	48.22	0	0
2025	4	2	5	23	9	28	0	0	0	0	0	0	0	48.15	0	0
2025	4	2	5	33	9	28	0	0	0	0	0	0	0	48.07	0	0
2025	4	2	5	43	9	28	0	0	0	0	0	0	0	48	0	0
2025	4	2	5	53	9	28	0	0	0	0	0	0	0	47.95	0	0
2025	4	2	6	3	9	27	0	0	0	0	0	0	0	47.88	0	0
2025	4	2	6	13	9	27	0	0	0	0	0	0	0	47.84	0	0
2025	4	2	6	23	9	28	0	0	0	0	0	0	0	47.77	0	0
2025	4	2	6	33	9	27	0	0	0	0	0	0	0	47.73	0	0
2025	4	2	6	43	9	27	0	0	0	0	0	0	0	47.68	0	0
2025	4	2	6	53	9	28	0	0	0	0	0	0	0	47.64	0	0
2025	4	2	7	3	9	28	0	0	0	0	0	0	0	47.62	0	0
2025	4	2	7	13	9	28	0	0	0	0	0	0	0	47.61	0	0
2025	4	2	7	23	9	27	0	0	0	0	0	0	0	47.61	0	0
2025	4	2	7	33	9	28	0	0	0	0	0	0	0	47.61	0	0
2025	4	2	7	43	9	27	0	0	0	0	0	0	0	47.62	0	0
2025	4	2	7	53	9	28	0	0	0	0	0	0	0	47.64	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	2	8	3	9	28	0	0	0	0	0	0	0	47.68	0	0
2025	4	2	8	13	9	28	0	0	0	0	0	0	0	47.73	0	0
2025	4	2	8	23	9	28	0	0	0	0	0	0	0	47.8	0	0
2025	4	2	8	33	9	28	0	0	0	0	0	0	0	47.88	0	0
2025	4	2	8	43	9	28	0	0	0	0	0	0	0	47.97	0	0
2025	4	2	8	53	9	28	0	0	0	0	0	0	0	48.06	0	0
2025	4	2	9	3	9	28	0	0	0	0	0	0	0	48.16	0	0
2025	4	2	9	13	9	28	0	0	0	0	0	0	0	48.29	0	0
2025	4	2	9	23	9	28	0	0	0	0	0	0	0	48.43	0	0
2025	4	2	9	33	9	28	0	0	0	0	0	0	0	48.56	0	0
2025	4	2	9	43	9	27	0	0	0	0	0	0	0	48.72	0	0
2025	4	2	9	53	9	28	0	0	0	0	0	0	0	48.87	0	0
2025	4	2	10	3	9	27	0	0	0	0	0	0	0	49.03	0	0
2025	4	2	10	13	9	27	0	0	0	0	0	0	0	49.23	0	0
2025	4	2	10	23	9	28	0	0	0	0	0	0	0	49.39	0	0
2025	4	2	10	33	9	27	0	0	0	0	0	0	0	49.59	0	0
2025	4	2	10	43	9	28	0	0	0	0	0	0	0	49.78	0	0
2025	4	2	10	53	9	28	0	0	0	0	0	0	0	49.98	0	0
2025	4	2	11	3	9	28	0	0	0	0	0	0	0	50.2	0	0
2025	4	2	11	13	9	28	0	0	0	0	0	0	0	50.41	0	0
2025	4	2	11	23	9	28	0	0	0	0	0	0	0	50.63	0	0
2025	4	2	11	33	9	27	0	0	0	0	0	0	0	50.85	0	0
2025	4	2	11	43	9	28	0	0	0	0	0	0	0	51.03	0	0
2025	4	2	11	53	9	28	0	0	0	0	0	0	0	51.17	0	0
2025	4	2	12	3	9	27	0	0	0	0	0	0	0	51.3	0	0
2025	4	2	12	13	9	27	0	0	0	0	0	0	0	51.42	0	0
2025	4	2	12	23	9	27	0	0	0	0	0	0	0	51.53	0	0
2025	4	2	12	33	9	27	0	0	0	0	0	0	0	51.62	0	0
2025	4	2	12	43	9	27	0	0	0	0	0	0	0	51.73	0	0
2025	4	2	12	53	9	27	0	0	0	0	0	0	0	51.84	0	0
2025	4	2	13	3	9	27	0	0	0	0	0	0	0	51.98	0	0
2025	4	2	13	13	9	27	0	0	0	0	0	0	0	52.14	0	0
2025	4	2	13	23	9	28	0	0	0	0	0	0	0	52.25	0	0
2025	4	2	13	33	9	27	0	0	0	0	0	0	0	52.32	0	0
2025	4	2	13	43	9	26	0	0	0	0	0	0	0	52.36	0	0
2025	4	2	13	53	9	28	0	0	0	0	0	0	0	52.38	0	0
2025	4	2	14	3	9	27	0	0	0	0	0	0	0	52.41	0	0
2025	4	2	14	13	9	27	0	0	0	0	0	0	0	52.47	0	0
2025	4	2	14	23	9	27	0	0	0	0	0	0	0	52.5	0	0
2025	4	2	14	33	9	27	0	0	0	0	0	0	0	52.54	0	0
2025	4	2	14	43	9	28	0	0	0	0	0	0	0	52.57	0	0
2025	4	2	14	53	9	27	0	0	0	0	0	0	0	52.63	0	0
2025	4	2	15	3	9	27	0	0	0	0	0	0	0	52.68	0	0
2025	4	2	15	13	9	27	0	0	0	0	0	0	0	52.72	0	0
2025	4	2	15	23	9	27	0	0	0	0	0	0	0	52.72	0	0
2025	4	2	15	33	9	27	0	0	0	0	0	0	0	52.7	0	0
2025	4	2	15	43	9	28	0	0	0	0	0	0	0	52.72	0	0
2025	4	2	15	53	9	28	0	0	0	0	0	0	0	52.72	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	2	16	3	9	27	0	0	0	0	0	0	0	52.72	0	0
2025	4	2	16	13	9	27	0	0	0	0	0	0	0	52.7	0	0
2025	4	2	16	23	9	27	0	0	0	0	0	0	0	52.7	0	0
2025	4	2	16	33	9	27	0	0	0	0	0	0	0	52.74	0	0
2025	4	2	16	43	9	28	0	0	0	0	0	0	0	52.75	0	0
2025	4	2	16	53	9	28	0	0	0	0	0	0	0	52.75	0	0
2025	4	2	17	3	9	27	0	0	0	0	0	0	0	52.74	0	0
2025	4	2	17	13	9	27	0	0	0	0	0	0	0	52.7	0	0
2025	4	2	17	23	9	27	0	0	0	0	0	0	0	52.68	0	0
2025	4	2	17	33	9	28	0	0	0	0	0	0	0	52.65	0	0
2025	4	2	17	43	9	27	0	0	0	0	0	0	0	52.61	0	0
2025	4	2	17	53	9	27	0	0	0	0	0	0	0	52.57	0	0
2025	4	2	18	3	9	27	0	0	0	0	0	0	0	52.54	0	0
2025	4	2	18	13	9	26	0	0	0	0	0	0	0	52.48	0	0
2025	4	2	18	23	9	27	0	0	0	0	0	0	0	52.41	0	0
2025	4	2	18	33	9	27	0	0	0	0	0	0	0	52.36	0	0
2025	4	2	18	43	9	27	0	0	0	0	0	0	0	52.29	0	0
2025	4	2	18	53	9	27	0	0	0	0	0	0	0	52.21	0	0
2025	4	2	19	3	9	27	0	0	0	0	0	0	0	52.12	0	0
2025	4	2	19	13	9	27	0	0	0	0	0	0	0	52.05	0	0
2025	4	2	19	23	9	28	0	0	0	0	0	0	0	52	0	0
2025	4	2	19	33	9	27	0	0	0	0	0	0	0	51.93	0	0
2025	4	2	19	43	9	28	0	0	0	0	0	0	0	51.82	0	0
2025	4	2	19	53	9	27	0	0	0	0	0	0	0	51.73	0	0
2025	4	2	20	3	9	27	0	0	0	0	0	0	0	51.64	0	0
2025	4	2	20	13	9	28	0	0	0	0	0	0	0	51.53	0	0
2025	4	2	20	23	9	27	0	0	0	0	0	0	0	51.42	0	0
2025	4	2	20	33	9	27	0	0	0	0	0	0	0	51.33	0	0
2025	4	2	20	43	9	27	0	0	0	0	0	0	0	51.22	0	0
2025	4	2	20	53	9	27	0	0	0	0	0	0	0	51.13	0	0
2025	4	2	21	3	9	27	0	0	0	0	0	0	0	51.01	0	0
2025	4	2	21	13	9	27	0	0	0	0	0	0	0	50.9	0	0
2025	4	2	21	23	9	27	0	0	0	0	0	0	0	50.79	0	0
2025	4	2	21	33	9	27	0	0	0	0	0	0	0	50.68	0	0
2025	4	2	21	43	9	27	0	0	0	0	0	0	0	50.58	0	0
2025	4	2	21	53	9	27	0	0	0	0	0	0	0	50.47	0	0
2025	4	2	22	3	9	27	0	0	0	0	0	0	0	50.36	0	0
2025	4	2	22	13	9	28	0	0	0	0	0	0	0	50.27	0	0
2025	4	2	22	23	9	27	0	0	0	0	0	0	0	50.16	0	0
2025	4	2	22	33	9	27	0	0	0	0	0	0	0	50.07	0	0
2025	4	2	22	43	9	28	0	0	0	0	0	0	0	49.96	0	0
2025	4	2	22	53	9	27	0	0	0	0	0	0	0	49.86	0	0
2025	4	2	23	3	9	27	0	0	0	0	0	0	0	49.77	0	0
2025	4	2	23	13	9	27	0	0	0	0	0	0	0	49.68	0	0
2025	4	2	23	23	9	28	0	0	0	0	0	0	0	49.57	0	0
2025	4	2	23	33	9	28	0	0	0	0	0	0	0	49.46	0	0
2025	4	2	23	43	9	28	0	0	0	0	0	0	0	49.37	0	0
2025	4	2	23	53	9	27	0	0	0	0	0	0	0	49.28	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	3	0	3	9	27	0	0	0	0	0	0	0	49.19	0	0
2025	4	3	0	13	9	28	0	0	0	0	0	0	0	49.08	0	0
2025	4	3	0	23	9	28	0	0	0	0	0	0	0	48.99	0	0
2025	4	3	0	33	9	27	0	0	0	0	0	0	0	48.9	0	0
2025	4	3	0	43	9	28	0	0	0	0	0	0	0	48.79	0	0
2025	4	3	0	53	9	28	0	0	0	0	0	0	0	48.7	0	0
2025	4	3	1	3	9	27	0	0	0	0	0	0	0	48.61	0	0
2025	4	3	1	13	9	28	0	0	0	0	0	0	0	48.51	0	0
2025	4	3	1	23	9	27	0	0	0	0	0	0	0	48.43	0	0
2025	4	3	1	33	9	27	0	0	0	0	0	0	0	48.33	0	0
2025	4	3	1	43	9	28	0	0	0	0	0	0	0	48.24	0	0
2025	4	3	1	53	9	27	0	0	0	0	0	0	0	48.15	0	0
2025	4	3	2	3	9	28	0	0	0	0	0	0	0	48.06	0	0
2025	4	3	2	13	9	28	0	0	0	0	0	0	0	47.98	0	0
2025	4	3	2	23	9	28	0	0	0	0	0	0	0	47.89	0	0
2025	4	3	2	33	9	28	0	0	0	0	0	0	0	47.8	0	0
2025	4	3	2	43	9	28	0	0	0	0	0	0	0	47.71	0	0
2025	4	3	2	53	9	28	0	0	0	0	0	0	0	47.62	0	0
2025	4	3	3	3	9	28	0	0	0	0	0	0	0	47.55	0	0
2025	4	3	3	13	9	28	0	0	0	0	0	0	0	47.46	0	0
2025	4	3	3	23	9	28	0	0	0	0	0	0	0	47.37	0	0
2025	4	3	3	33	9	27	0	0	0	0	0	0	0	47.3	0	0
2025	4	3	3	43	9	27	0	0	0	0	0	0	0	47.21	0	0
2025	4	3	3	53	9	28	0	0	0	0	0	0	0	47.14	0	0
2025	4	3	4	3	9	28	0	0	0	0	0	0	0	47.07	0	0
2025	4	3	4	13	9	28	0	0	0	0	0	0	0	47.01	0	0
2025	4	3	4	23	9	27	0	0	0	0	0	0	0	46.94	0	0
2025	4	3	4	33	9	27	0	0	0	0	0	0	0	46.89	0	0
2025	4	3	4	43	9	28	0	0	0	0	0	0	0	46.83	0	0
2025	4	3	4	53	9	27	0	0	0	0	0	0	0	46.78	0	0
2025	4	3	5	3	9	28	0	0	0	0	0	0	0	46.72	0	0
2025	4	3	5	13	9	28	0	0	0	0	0	0	0	46.67	0	0
2025	4	3	5	23	9	28	0	0	0	0	0	0	0	46.6	0	0
2025	4	3	5	33	9	27	0	0	0	0	0	0	0	46.56	0	0
2025	4	3	5	43	9	28	0	0	0	0	0	0	0	46.53	0	0
2025	4	3	5	53	9	27	0	0	0	0	0	0	0	46.47	0	0
2025	4	3	6	3	9	28	0	0	0	0	0	0	0	46.44	0	0
2025	4	3	6	13	9	28	0	0	0	0	0	0	0	46.4	0	0
2025	4	3	6	23	9	28	0	0	0	0	0	0	0	46.36	0	0
2025	4	3	6	33	9	27	0	0	0	0	0	0	0	46.33	0	0
2025	4	3	6	43	9	28	0	0	0	0	0	0	0	46.29	0	0
2025	4	3	6	53	9	27	0	0	0	0	0	0	0	46.26	0	0
2025	4	3	7	3	9	28	0	0	0	0	0	0	0	46.26	0	0
2025	4	3	7	13	9	28	0	0	0	0	0	0	0	46.24	0	0
2025	4	3	7	23	9	28	0	0	0	0	0	0	0	46.26	0	0
2025	4	3	7	33	9	28	0	0	0	0	0	0	0	46.26	0	0
2025	4	3	7	43	9	28	0	0	0	0	0	0	0	46.27	0	0
2025	4	3	7	53	9	28	0	0	0	0	0	0	0	46.33	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	3	8	3	9	28	0	0	0	0	0	0	0	46.36	0	0
2025	4	3	8	13	9	27	0	0	0	0	0	0	0	46.42	0	0
2025	4	3	8	23	9	28	0	0	0	0	0	0	0	46.47	0	0
2025	4	3	8	33	9	28	0	0	0	0	0	0	0	46.54	0	0
2025	4	3	8	43	9	27	0	0	0	0	0	0	0	46.63	0	0
2025	4	3	8	53	9	28	0	0	0	0	0	0	0	46.72	0	0
2025	4	3	9	3	9	28	0	0	0	0	0	0	0	46.83	0	0
2025	4	3	9	13	9	28	0	0	0	0	0	0	0	46.96	0	0
2025	4	3	9	23	9	28	0	0	0	0	0	0	0	47.08	0	0
2025	4	3	9	33	9	28	0	0	0	0	0	0	0	47.21	0	0
2025	4	3	9	43	9	28	0	0	0	0	0	0	0	47.37	0	0
2025	4	3	9	53	9	28	0	0	0	0	0	0	0	47.53	0	0
2025	4	3	10	3	9	28	0	0	0	0	0	0	0	47.7	0	0
2025	4	3	10	13	9	28	0	0	0	0	0	0	0	47.88	0	0
2025	4	3	10	23	9	29	0	0	0	0	0	0	0	48.06	0	0
2025	4	3	10	33	9	28	0	0	0	0	0	0	0	48.25	0	0
2025	4	3	10	43	9	28	0	0	0	0	0	0	0	48.45	0	0
2025	4	3	10	53	9	26	0	0	0	0	0	0	0	48.67	0	0
2025	4	3	11	3	9	27	0	0	0	0	0	0	0	48.87	0	0
2025	4	3	11	13	9	27	0	0	0	0	0	0	0	49.1	0	0
2025	4	3	11	23	9	28	0	0	0	0	0	0	0	49.33	0	0
2025	4	3	11	33	9	27	0	0	0	0	0	0	0	49.55	0	0
2025	4	3	11	43	9	27	0	0	0	0	0	0	0	49.78	0	0
2025	4	3	11	53	9	27	0	0	0	0	0	0	0	50.04	0	0
2025	4	3	12	3	9	28	0	0	0	0	0	0	0	50.27	0	0
2025	4	3	12	13	9	27	0	0	0	0	0	0	0	50.5	0	0
2025	4	3	12	23	9	28	0	0	0	0	0	0	0	50.76	0	0
2025	4	3	12	33	9	27	0	0	0	0	0	0	0	50.99	0	0
2025	4	3	12	43	9	28	0	0	0	0	0	0	0	51.22	0	0
2025	4	3	12	53	9	27	0	0	0	0	0	0	0	51.48	0	0
2025	4	3	13	3	9	27	0	0	0	0	0	0	0	51.69	0	0
2025	4	3	13	13	9	27	0	0	0	0	0	0	0	51.93	0	0
2025	4	3	13	23	9	27	0	0	0	0	0	0	0	52.16	0	0
2025	4	3	13	33	9	27	0	0	0	0	0	0	0	52.38	0	0
2025	4	3	13	43	9	27	0	0	0	0	0	0	0	52.61	0	0
2025	4	3	13	53	9	27	0	0	0	0	0	0	0	52.83	0	0
2025	4	3	14	3	9	28	0	0	0	0	0	0	0	53.04	0	0
2025	4	3	14	13	9	26	0	0	0	0	0	0	0	53.24	0	0
2025	4	3	14	23	9	27	0	0	0	0	0	0	0	53.42	0	0
2025	4	3	14	33	9	27	0	0	0	0	0	0	0	53.62	0	0
2025	4	3	14	43	9	27	0	0	0	0	0	0	0	53.76	0	0
2025	4	3	14	53	9	28	0	0	0	0	0	0	0	53.91	0	0
2025	4	3	15	3	9	27	0	0	0	0	0	0	0	54.03	0	0
2025	4	3	15	13	9	28	0	0	0	0	0	0	0	54.16	0	0
2025	4	3	15	23	9	27	0	0	0	0	0	0	0	54.3	0	0
2025	4	3	15	33	9	27	0	0	0	0	0	0	0	54.41	0	0
2025	4	3	15	43	9	26	0	0	0	0	0	0	0	54.45	0	0
2025	4	3	15	53	9	27	0	0	0	0	0	0	0	54.5	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	3	16	3	9	27	0	0	0	0	0	0	0	54.55	0	0
2025	4	3	16	13	9	27	0	0	0	0	0	0	0	54.55	0	0
2025	4	3	16	23	9	27	0	0	0	0	0	0	0	54.54	0	0
2025	4	3	16	33	9	27	0	0	0	0	0	0	0	54.55	0	0
2025	4	3	16	43	9	28	0	0	0	0	0	0	0	54.59	0	0
2025	4	3	16	53	9	27	0	0	0	0	0	0	0	54.61	0	0
2025	4	3	17	3	9	27	0	0	0	0	0	0	0	54.59	0	0
2025	4	3	17	13	9	27	0	0	0	0	0	0	0	54.59	0	0
2025	4	3	17	23	9	28	0	0	0	0	0	0	0	54.57	0	0
2025	4	3	17	33	9	27	0	0	0	0	0	0	0	54.55	0	0
2025	4	3	17	43	9	27	0	0	0	0	0	0	0	54.54	0	0
2025	4	3	17	53	9	27	0	0	0	0	0	0	0	54.5	0	0
2025	4	3	18	3	9	27	0	0	0	0	0	0	0	54.45	0	0
2025	4	3	18	13	9	27	0	0	0	0	0	0	0	54.39	0	0
2025	4	3	18	23	9	27	0	0	0	0	0	0	0	54.32	0	0
2025	4	3	18	33	9	27	0	0	0	0	0	0	0	54.28	0	0
2025	4	3	18	43	9	28	0	0	0	0	0	0	0	54.25	0	0
2025	4	3	18	53	9	27	0	0	0	0	0	0	0	54.19	0	0
2025	4	3	19	3	9	28	0	0	0	0	0	0	0	54.16	0	0
2025	4	3	19	13	9	27	0	0	0	0	0	0	0	54.09	0	0
2025	4	3	19	23	9	27	0	0	0	0	0	0	0	54.03	0	0
2025	4	3	19	33	9	27	0	0	0	0	0	0	0	53.98	0	0
2025	4	3	19	43	9	27	0	0	0	0	0	0	0	53.91	0	0
2025	4	3	19	53	9	27	0	0	0	0	0	0	0	53.83	0	0
2025	4	3	20	3	9	28	0	0	0	0	0	0	0	53.74	0	0
2025	4	3	20	13	9	27	0	0	0	0	0	0	0	53.65	0	0
2025	4	3	20	23	9	28	0	0	0	0	0	0	0	53.56	0	0
2025	4	3	20	33	9	28	0	0	0	0	0	0	0	53.46	0	0
2025	4	3	20	43	9	27	0	0	0	0	0	0	0	53.38	0	0
2025	4	3	20	53	9	27	0	0	0	0	0	0	0	53.28	0	0
2025	4	3	21	3	9	27	0	0	0	0	0	0	0	53.17	0	0
2025	4	3	21	13	9	28	0	0	0	0	0	0	0	53.08	0	0
2025	4	3	21	23	9	27	0	0	0	0	0	0	0	52.97	0	0
2025	4	3	21	33	9	27	0	0	0	0	0	0	0	52.9	0	0
2025	4	3	21	43	9	27	0	0	0	0	0	0	0	52.83	0	0
2025	4	3	21	53	9	27	0	0	0	0	0	0	0	52.75	0	0
2025	4	3	22	3	9	27	0	0	0	0	0	0	0	52.66	0	0
2025	4	3	22	13	9	27	0	0	0	0	0	0	0	52.59	0	0
2025	4	3	22	23	9	27	0	0	0	0	0	0	0	52.52	0	0
2025	4	3	22	33	9	27	0	0	0	0	0	0	0	52.45	0	0
2025	4	3	22	43	9	27	0	0	0	0	0	0	0	52.38	0	0
2025	4	3	22	53	9	27	0	0	0	0	0	0	0	52.29	0	0
2025	4	3	23	3	9	27	0	0	0	0	0	0	0	52.18	0	0
2025	4	3	23	13	9	27	0	0	0	0	0	0	0	52.09	0	0
2025	4	3	23	23	9	27	0	0	0	0	0	0	0	52	0	0
2025	4	3	23	33	9	27	0	0	0	0	0	0	0	51.89	0	0
2025	4	3	23	43	9	27	0	0	0	0	0	0	0	51.8	0	0
2025	4	3	23	53	9	27	0	0	0	0	0	0	0	51.69	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	4	0	3	9	27	0	0	0	0	0	0	0	51.58	0	0
2025	4	4	0	13	9	27	0	0	0	0	0	0	0	51.48	0	0
2025	4	4	0	23	9	28	0	0	0	0	0	0	0	51.37	0	0
2025	4	4	0	33	9	27	0	0	0	0	0	0	0	51.26	0	0
2025	4	4	0	43	9	28	0	0	0	0	0	0	0	51.15	0	0
2025	4	4	0	53	9	27	0	0	0	0	0	0	0	51.06	0	0
2025	4	4	1	3	9	27	0	0	0	0	0	0	0	50.95	0	0
2025	4	4	1	13	9	28	0	0	0	0	0	0	0	50.86	0	0
2025	4	4	1	23	9	27	0	0	0	0	0	0	0	50.76	0	0
2025	4	4	1	33	9	27	0	0	0	0	0	0	0	50.65	0	0
2025	4	4	1	43	9	27	0	0	0	0	0	0	0	50.56	0	0
2025	4	4	1	53	9	27	0	0	0	0	0	0	0	50.47	0	0
2025	4	4	2	3	9	27	0	0	0	0	0	0	0	50.38	0	0
2025	4	4	2	13	9	27	0	0	0	0	0	0	0	50.31	0	0
2025	4	4	2	23	9	28	0	0	0	0	0	0	0	50.22	0	0
2025	4	4	2	33	9	27	0	0	0	0	0	0	0	50.13	0	0
2025	4	4	2	43	9	28	0	0	0	0	0	0	0	50.04	0	0
2025	4	4	2	53	9	27	0	0	0	0	0	0	0	49.98	0	0
2025	4	4	3	3	9	27	0	0	0	0	0	0	0	49.91	0	0
2025	4	4	3	13	9	27	0	0	0	0	0	0	0	49.84	0	0
2025	4	4	3	23	9	27	0	0	0	0	0	0	0	49.78	0	0
2025	4	4	3	33	9	28	0	0	0	0	0	0	0	49.73	0	0
2025	4	4	3	43	9	28	0	0	0	0	0	0	0	49.68	0	0
2025	4	4	3	53	9	28	0	0	0	0	0	0	0	49.62	0	0
2025	4	4	4	3	9	28	0	0	0	0	0	0	0	49.55	0	0
2025	4	4	4	13	9	27	0	0	0	0	0	0	0	49.5	0	0
2025	4	4	4	23	9	28	0	0	0	0	0	0	0	49.44	0	0
2025	4	4	4	33	9	27	0	0	0	0	0	0	0	49.39	0	0
2025	4	4	4	43	9	27	0	0	0	0	0	0	0	49.33	0	0
2025	4	4	4	53	9	27	0	0	0	0	0	0	0	49.28	0	0
2025	4	4	5	3	9	28	0	0	0	0	0	0	0	49.23	0	0
2025	4	4	5	13	9	28	0	0	0	0	0	0	0	49.17	0	0
2025	4	4	5	23	9	27	0	0	0	0	0	0	0	49.14	0	0
2025	4	4	5	33	9	27	0	0	0	0	0	0	0	49.06	0	0
2025	4	4	5	43	9	28	0	0	0	0	0	0	0	49.03	0	0
2025	4	4	5	53	9	27	0	0	0	0	0	0	0	48.99	0	0
2025	4	4	6	3	9	27	0	0	0	0	0	0	0	48.94	0	0
2025	4	4	6	13	9	27	0	0	0	0	0	0	0	48.9	0	0
2025	4	4	6	23	9	28	0	0	0	0	0	0	0	48.85	0	0
2025	4	4	6	33	9	28	0	0	0	0	0	0	0	48.83	0	0
2025	4	4	6	43	9	27	0	0	0	0	0	0	0	48.79	0	0
2025	4	4	6	53	9	27	0	0	0	0	0	0	0	48.78	0	0
2025	4	4	7	3	9	27	0	0	0	0	0	0	0	48.78	0	0
2025	4	4	7	13	9	27	0	0	0	0	0	0	0	48.78	0	0
2025	4	4	7	23	9	28	0	0	0	0	0	0	0	48.78	0	0
2025	4	4	7	33	9	27	0	0	0	0	0	0	0	48.79	0	0
2025	4	4	7	43	9	28	0	0	0	0	0	0	0	48.81	0	0
2025	4	4	7	53	9	27	0	0	0	0	0	0	0	48.85	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	4	8	3	9	28	0	0	0	0	0	0	0	48.9	0	0
2025	4	4	8	13	9	28	0	0	0	0	0	0	0	48.97	0	0
2025	4	4	8	23	9	27	0	0	0	0	0	0	0	49.03	0	0
2025	4	4	8	33	9	27	0	0	0	0	0	0	0	49.12	0	0
2025	4	4	8	43	9	27	0	0	0	0	0	0	0	49.23	0	0
2025	4	4	8	53	9	28	0	0	0	0	0	0	0	49.32	0	0
2025	4	4	9	3	9	27	0	0	0	0	0	0	0	49.44	0	0
2025	4	4	9	13	9	27	0	0	0	0	0	0	0	49.57	0	0
2025	4	4	9	23	9	28	0	0	0	0	0	0	0	49.69	0	0
2025	4	4	9	33	9	27	0	0	0	0	0	0	0	49.82	0	0
2025	4	4	9	43	9	28	0	0	0	0	0	0	0	50	0	0
2025	4	4	9	53	9	28	0	0	0	0	0	0	0	50.14	0	0
2025	4	4	10	3	9	28	0	0	0	0	0	0	0	50.22	0	0
2025	4	4	10	13	9	27	0	0	0	0	0	0	0	50.31	0	0
2025	4	4	10	23	9	27	0	0	0	0	0	0	0	50.43	0	0
2025	4	4	10	33	9	29	0	0	0	0	0	0	0	50.56	0	0
2025	4	4	10	43	9	27	0	0	0	0	0	0	0	50.68	0	0
2025	4	4	10	53	9	27	0	0	0	0	0	0	0	50.88	0	0
2025	4	4	11	3	9	27	0	0	0	0	0	0	0	51.01	0	0
2025	4	4	11	13	9	27	0	0	0	0	0	0	0	51.04	0	0
2025	4	4	11	23	9	28	0	0	0	0	0	0	0	51.13	0	0
2025	4	4	11	33	9	27	0	0	0	0	0	0	0	51.21	0	0
2025	4	4	11	43	9	27	0	0	0	0	0	0	0	51.28	0	0
2025	4	4	11	53	9	27	0	0	0	0	0	0	0	51.35	0	0
2025	4	4	12	3	9	28	0	0	0	0	0	0	0	51.42	0	0
2025	4	4	12	13	9	28	0	0	0	0	0	0	0	51.48	0	0
2025	4	4	12	23	9	28	0	0	0	0	0	0	0	51.57	0	0
2025	4	4	12	33	9	27	0	0	0	0	0	0	0	51.75	0	0
2025	4	4	12	43	9	27	0	0	0	0	0	0	0	51.85	0	0
2025	4	4	12	53	9	27	0	0	0	0	0	0	0	51.98	0	0
2025	4	4	13	3	9	27	0	0	0	0	0	0	0	52.11	0	0
2025	4	4	13	13	9	27	0	0	0	0	0	0	0	52.16	0	0
2025	4	4	13	23	9	27	0	0	0	0	0	0	0	52.21	0	0
2025	4	4	13	33	9	27	0	0	0	0	0	0	0	52.38	0	0
2025	4	4	13	43	9	28	0	0	0	0	0	0	0	52.52	0	0
2025	4	4	13	53	9	27	0	0	0	0	0	0	0	52.7	0	0
2025	4	4	14	3	9	28	0	0	0	0	0	0	0	52.88	0	0
2025	4	4	14	13	9	27	0	0	0	0	0	0	0	52.99	0	0
2025	4	4	14	23	9	27	0	0	0	0	0	0	0	53.11	0	0
2025	4	4	14	33	9	27	0	0	0	0	0	0	0	53.26	0	0
2025	4	4	14	43	9	27	0	0	0	0	0	0	0	53.35	0	0
2025	4	4	14	53	9	27	0	0	0	0	0	0	0	53.49	0	0
2025	4	4	15	3	9	27	0	0	0	0	0	0	0	53.65	0	0
2025	4	4	15	13	9	27	0	0	0	0	0	0	0	53.8	0	0
2025	4	4	15	23	9	28	0	0	0	0	0	0	0	53.92	0	0
2025	4	4	15	33	9	27	0	0	0	0	0	0	0	54.01	0	0
2025	4	4	15	43	9	27	0	0	0	0	0	0	0	54.14	0	0
2025	4	4	15	53	9	27	0	0	0	0	0	0	0	54.23	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	4	16	3	9	27	0	0	0	0	0	0	0	54.32	0	0
2025	4	4	16	13	9	27	0	0	0	0	0	0	0	54.39	0	0
2025	4	4	16	23	9	27	0	0	0	0	0	0	0	54.45	0	0
2025	4	4	16	33	9	27	0	0	0	0	0	0	0	54.48	0	0
2025	4	4	16	43	9	27	0	0	0	0	0	0	0	54.5	0	0
2025	4	4	16	53	9	27	0	0	0	0	0	0	0	54.48	0	0
2025	4	4	17	3	9	27	0	0	0	0	0	0	0	54.46	0	0
2025	4	4	17	13	9	26	0	0	0	0	0	0	0	54.45	0	0
2025	4	4	17	23	9	27	0	0	0	0	0	0	0	54.41	0	0
2025	4	4	17	33	9	27	0	0	0	0	0	0	0	54.36	0	0
2025	4	4	17	43	9	27	0	0	0	0	0	0	0	54.3	0	0
2025	4	4	17	53	9	27	0	0	0	0	0	0	0	54.25	0	0
2025	4	4	18	3	9	27	0	0	0	0	0	0	0	54.18	0	0
2025	4	4	18	13	9	27	0	0	0	0	0	0	0	54.12	0	0
2025	4	4	18	23	9	27	0	0	0	0	0	0	0	54.05	0	0
2025	4	4	18	33	9	27	0	0	0	0	0	0	0	53.98	0	0
2025	4	4	18	43	9	27	0	0	0	0	0	0	0	53.91	0	0
2025	4	4	18	53	9	27	0	0	0	0	0	0	0	53.83	0	0
2025	4	4	19	3	9	27	0	0	0	0	0	0	0	53.76	0	0
2025	4	4	19	13	9	27	0	0	0	0	0	0	0	53.69	0	0
2025	4	4	19	23	9	27	0	0	0	0	0	0	0	53.62	0	0
2025	4	4	19	33	9	27	0	0	0	0	0	0	0	53.55	0	0
2025	4	4	19	43	9	27	0	0	0	0	0	0	0	53.47	0	0
2025	4	4	19	53	9	27	0	0	0	0	0	0	0	53.42	0	0
2025	4	4	20	3	9	27	0	0	0	0	0	0	0	53.35	0	0
2025	4	4	20	13	9	27	0	0	0	0	0	0	0	53.28	0	0
2025	4	4	20	23	9	28	0	0	0	0	0	0	0	53.22	0	0
2025	4	4	20	33	9	27	0	0	0	0	0	0	0	53.15	0	0
2025	4	4	20	43	9	27	0	0	0	0	0	0	0	53.06	0	0
2025	4	4	20	53	9	27	0	0	0	0	0	0	0	52.99	0	0
2025	4	4	21	3	9	28	0	0	0	0	0	0	0	52.9	0	0
2025	4	4	21	13	9	27	0	0	0	0	0	0	0	52.79	0	0
2025	4	4	21	23	9	26	0	0	0	0	0	0	0	52.68	0	0
2025	4	4	21	33	9	27	0	0	0	0	0	0	0	52.57	0	0
2025	4	4	21	43	9	27	0	0	0	0	0	0	0	52.47	0	0
2025	4	4	21	53	9	28	0	0	0	0	0	0	0	52.34	0	0
2025	4	4	22	3	9	28	0	0	0	0	0	0	0	52.23	0	0
2025	4	4	22	13	9	27	0	0	0	0	0	0	0	52.12	0	0
2025	4	4	22	23	9	28	0	0	0	0	0	0	0	52	0	0
2025	4	4	22	33	9	27	0	0	0	0	0	0	0	51.89	0	0
2025	4	4	22	43	9	27	0	0	0	0	0	0	0	51.76	0	0
2025	4	4	22	53	9	27	0	0	0	0	0	0	0	51.66	0	0
2025	4	4	23	3	9	27	0	0	0	0	0	0	0	51.53	0	0
2025	4	4	23	13	9	27	0	0	0	0	0	0	0	51.42	0	0
2025	4	4	23	23	9	27	0	0	0	0	0	0	0	51.3	0	0
2025	4	4	23	33	9	28	0	0	0	0	0	0	0	51.19	0	0
2025	4	4	23	43	9	27	0	0	0	0	0	0	0	51.06	0	0
2025	4	4	23	53	9	28	0	0	0	0	0	0	0	50.95	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	5	0	3	9	27	0	0	0	0	0	0	0	50.85	0	0
2025	4	5	0	13	9	27	0	0	0	0	0	0	0	50.72	0	0
2025	4	5	0	23	9	27	0	0	0	0	0	0	0	50.61	0	0
2025	4	5	0	33	9	27	0	0	0	0	0	0	0	50.52	0	0
2025	4	5	0	43	9	28	0	0	0	0	0	0	0	50.41	0	0
2025	4	5	0	53	9	27	0	0	0	0	0	0	0	50.32	0	0
2025	4	5	1	3	9	27	0	0	0	0	0	0	0	50.23	0	0
2025	4	5	1	13	9	27	0	0	0	0	0	0	0	50.16	0	0
2025	4	5	1	23	9	27	0	0	0	0	0	0	0	50.09	0	0
2025	4	5	1	33	9	28	0	0	0	0	0	0	0	50	0	0
2025	4	5	1	43	9	28	0	0	0	0	0	0	0	49.91	0	0
2025	4	5	1	53	9	28	0	0	0	0	0	0	0	49.86	0	0
2025	4	5	2	3	9	27	0	0	0	0	0	0	0	49.78	0	0
2025	4	5	2	13	9	27	0	0	0	0	0	0	0	49.73	0	0
2025	4	5	2	23	9	27	0	0	0	0	0	0	0	49.68	0	0
2025	4	5	2	33	9	27	0	0	0	0	0	0	0	49.64	0	0
2025	4	5	2	43	9	28	0	0	0	0	0	0	0	49.59	0	0
2025	4	5	2	53	9	27	0	0	0	0	0	0	0	49.55	0	0
2025	4	5	3	3	9	27	0	0	0	0	0	0	0	49.5	0	0
2025	4	5	3	13	9	27	0	0	0	0	0	0	0	49.46	0	0
2025	4	5	3	23	9	28	0	0	0	0	0	0	0	49.41	0	0
2025	4	5	3	33	9	27	0	0	0	0	0	0	0	49.37	0	0
2025	4	5	3	43	9	27	0	0	0	0	0	0	0	49.35	0	0
2025	4	5	3	53	9	28	0	0	0	0	0	0	0	49.33	0	0
2025	4	5	4	3	9	28	0	0	0	0	0	0	0	49.3	0	0
2025	4	5	4	13	9	27	0	0	0	0	0	0	0	49.28	0	0
2025	4	5	4	23	9	27	0	0	0	0	0	0	0	49.26	0	0
2025	4	5	4	33	9	28	0	0	0	0	0	0	0	49.24	0	0
2025	4	5	4	43	9	28	0	0	0	0	0	0	0	49.21	0	0
2025	4	5	4	53	9	27	0	0	0	0	0	0	0	49.21	0	0
2025	4	5	5	3	9	27	0	0	0	0	0	0	0	49.17	0	0
2025	4	5	5	13	9	27	0	0	0	0	0	0	0	49.14	0	0
2025	4	5	5	23	9	28	0	0	0	0	0	0	0	49.12	0	0
2025	4	5	5	33	9	27	0	0	0	0	0	0	0	49.08	0	0
2025	4	5	5	43	9	27	0	0	0	0	0	0	0	49.06	0	0
2025	4	5	5	53	9	27	0	0	0	0	0	0	0	49.03	0	0
2025	4	5	6	3	9	27	0	0	0	0	0	0	0	48.99	0	0
2025	4	5	6	13	9	28	0	0	0	0	0	0	0	48.96	0	0
2025	4	5	6	23	9	27	0	0	0	0	0	0	0	48.92	0	0
2025	4	5	6	33	9	28	0	0	0	0	0	0	0	48.88	0	0
2025	4	5	6	43	9	28	0	0	0	0	0	0	0	48.87	0	0
2025	4	5	6	53	9	28	0	0	0	0	0	0	0	48.85	0	0
2025	4	5	7	3	9	28	0	0	0	0	0	0	0	48.85	0	0
2025	4	5	7	13	9	28	0	0	0	0	0	0	0	48.83	0	0
2025	4	5	7	23	9	28	0	0	0	0	0	0	0	48.85	0	0
2025	4	5	7	33	9	28	0	0	0	0	0	0	0	48.87	0	0
2025	4	5	7	43	9	27	0	0	0	0	0	0	0	48.9	0	0
2025	4	5	7	53	9	27	0	0	0	0	0	0	0	48.96	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	5	8	3	9	27	0	0	0	0	0	0	0	49.01	0	0
2025	4	5	8	13	9	28	0	0	0	0	0	0	0	49.08	0	0
2025	4	5	8	23	9	28	0	0	0	0	0	0	0	49.17	0	0
2025	4	5	8	33	9	28	0	0	0	0	0	0	0	49.26	0	0
2025	4	5	8	43	9	27	0	0	0	0	0	0	0	49.37	0	0
2025	4	5	8	53	9	27	0	0	0	0	0	0	0	49.5	0	0
2025	4	5	9	3	9	27	0	0	0	0	0	0	0	49.64	0	0
2025	4	5	9	13	9	27	0	0	0	0	0	0	0	49.78	0	0
2025	4	5	9	23	9	27	0	0	0	0	0	0	0	49.93	0	0
2025	4	5	9	33	9	28	0	0	0	0	0	0	0	50.09	0	0
2025	4	5	9	43	9	28	0	0	0	0	0	0	0	50.27	0	0
2025	4	5	9	53	9	27	0	0	0	0	0	0	0	50.43	0	0
2025	4	5	10	3	9	28	0	0	0	0	0	0	0	50.63	0	0
2025	4	5	10	13	9	28	0	0	0	0	0	0	0	50.83	0	0
2025	4	5	10	23	9	28	0	0	0	0	0	0	0	51.03	0	0
2025	4	5	10	33	9	27	0	0	0	0	0	0	0	51.24	0	0
2025	4	5	10	43	9	28	0	0	0	0	0	0	0	51.44	0	0
2025	4	5	10	53	9	27	0	0	0	0	0	0	0	51.67	0	0
2025	4	5	11	3	9	27	0	0	0	0	0	0	0	51.89	0	0
2025	4	5	11	13	9	28	0	0	0	0	0	0	0	52.11	0	0
2025	4	5	11	23	9	27	0	0	0	0	0	0	0	52.34	0	0
2025	4	5	11	33	9	27	0	0	0	0	0	0	0	52.57	0	0
2025	4	5	11	43	9	27	0	0	0	0	0	0	0	52.83	0	0
2025	4	5	11	53	9	27	0	0	0	0	0	0	0	53.04	0	0
2025	4	5	12	3	9	27	0	0	0	0	0	0	0	53.28	0	0
2025	4	5	12	13	9	27	0	0	0	0	0	0	0	53.53	0	0
2025	4	5	12	23	9	26	0	0	0	0	0	0	0	53.76	0	0
2025	4	5	12	33	9	27	0	0	0	0	0	0	0	54	0	0
2025	4	5	12	43	9	28	0	0	0	0	0	0	0	54.25	0	0
2025	4	5	12	53	9	27	0	0	0	0	0	0	0	54.48	0	0
2025	4	5	13	3	9	27	0	0	0	0	0	0	0	54.72	0	0
2025	4	5	13	13	9	27	0	0	0	0	0	0	0	54.93	0	0
2025	4	5	13	23	9	27	0	0	0	0	0	0	0	55.18	0	0
2025	4	5	13	33	9	27	0	0	0	0	0	0	0	55.4	0	0
2025	4	5	13	43	9	26	0	0	0	0	0	0	0	55.62	0	0
2025	4	5	13	53	9	27	0	0	0	0	0	0	0	55.83	0	0
2025	4	5	14	3	9	27	0	0	0	0	0	0	0	56.05	0	0
2025	4	5	14	13	9	27	0	0	0	0	0	0	0	56.25	0	0
2025	4	5	14	23	9	27	0	0	0	0	0	0	0	56.43	0	0
2025	4	5	14	33	9	27	0	0	0	0	0	0	0	56.61	0	0
2025	4	5	14	43	9	27	0	0	0	0	0	0	0	56.77	0	0
2025	4	5	14	53	9	27	0	0	0	0	0	0	0	56.93	0	0
2025	4	5	15	3	9	26	0	0	0	0	0	0	0	57.09	0	0
2025	4	5	15	13	9	27	0	0	0	0	0	0	0	57.2	0	0
2025	4	5	15	23	9	27	0	0	0	0	0	0	0	57.33	0	0
2025	4	5	15	33	9	27	0	0	0	0	0	0	0	57.45	0	0
2025	4	5	15	43	9	27	0	0	0	0	0	0	0	57.54	0	0
2025	4	5	15	53	9	27	0	0	0	0	0	0	0	57.65	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	5	16	3	9	27	0	0	0	0	0	0	0	57.72	0	0
2025	4	5	16	13	9	26	0	0	0	0	0	0	0	57.79	0	0
2025	4	5	16	23	9	27	0	0	0	0	0	0	0	57.87	0	0
2025	4	5	16	33	9	27	0	0	0	0	0	0	0	57.92	0	0
2025	4	5	16	43	9	27	0	0	0	0	0	0	0	57.96	0	0
2025	4	5	16	53	9	26	0	0	0	0	0	0	0	57.97	0	0
2025	4	5	17	3	9	26	0	0	0	0	0	0	0	58.01	0	0
2025	4	5	17	13	9	27	0	0	0	0	0	0	0	57.99	0	0
2025	4	5	17	23	9	26	0	0	0	0	0	0	0	57.97	0	0
2025	4	5	17	33	9	26	0	0	0	0	0	0	0	57.97	0	0
2025	4	5	17	43	9	27	0	0	0	0	0	0	0	57.96	0	0
2025	4	5	17	53	9	26	0	0	0	0	0	0	0	57.94	0	0
2025	4	5	18	3	9	27	0	0	0	0	0	0	0	57.9	0	0
2025	4	5	18	13	9	26	0	0	0	0	0	0	0	57.85	0	0
2025	4	5	18	23	9	26	0	0	0	0	0	0	0	57.79	0	0
2025	4	5	18	33	9	27	0	0	0	0	0	0	0	57.74	0	0
2025	4	5	18	43	9	27	0	0	0	0	0	0	0	57.67	0	0
2025	4	5	18	53	9	27	0	0	0	0	0	0	0	57.6	0	0
2025	4	5	19	3	9	26	0	0	0	0	0	0	0	57.54	0	0
2025	4	5	19	13	9	27	0	0	0	0	0	0	0	57.47	0	0
2025	4	5	19	23	9	26	0	0	0	0	0	0	0	57.4	0	0
2025	4	5	19	33	9	26	0	0	0	0	0	0	0	57.31	0	0
2025	4	5	19	43	9	27	0	0	0	0	0	0	0	57.22	0	0
2025	4	5	19	53	9	28	0	0	0	0	0	0	0	57.11	0	0
2025	4	5	20	3	9	27	0	0	0	0	0	0	0	57	0	0
2025	4	5	20	13	9	26	0	0	0	0	0	0	0	56.89	0	0
2025	4	5	20	23	9	26	0	0	0	0	0	0	0	56.79	0	0
2025	4	5	20	33	9	27	0	0	0	0	0	0	0	56.68	0	0
2025	4	5	20	43	9	26	0	0	0	0	0	0	0	56.55	0	0
2025	4	5	20	53	9	27	0	0	0	0	0	0	0	56.44	0	0
2025	4	5	21	3	9	27	0	0	0	0	0	0	0	56.3	0	0
2025	4	5	21	13	9	27	0	0	0	0	0	0	0	56.19	0	0
2025	4	5	21	23	9	27	0	0	0	0	0	0	0	56.07	0	0
2025	4	5	21	33	9	27	0	0	0	0	0	0	0	55.96	0	0
2025	4	5	21	43	9	26	0	0	0	0	0	0	0	55.81	0	0
2025	4	5	21	53	9	26	0	0	0	0	0	0	0	55.69	0	0
2025	4	5	22	3	9	27	0	0	0	0	0	0	0	55.56	0	0
2025	4	5	22	13	9	27	0	0	0	0	0	0	0	55.44	0	0
2025	4	5	22	23	9	27	0	0	0	0	0	0	0	55.31	0	0
2025	4	5	22	33	9	27	0	0	0	0	0	0	0	55.17	0	0
2025	4	5	22	43	9	27	0	0	0	0	0	0	0	55.04	0	0
2025	4	5	22	53	9	27	0	0	0	0	0	0	0	54.91	0	0
2025	4	5	23	3	9	27	0	0	0	0	0	0	0	54.75	0	0
2025	4	5	23	13	9	27	0	0	0	0	0	0	0	54.63	0	0
2025	4	5	23	23	9	27	0	0	0	0	0	0	0	54.5	0	0
2025	4	5	23	33	9	27	0	0	0	0	0	0	0	54.36	0	0
2025	4	5	23	43	9	27	0	0	0	0	0	0	0	54.21	0	0
2025	4	5	23	53	9	27	0	0	0	0	0	0	0	54.05	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	6	0	3	9	27	0	0	0	0	0	0	0	53.92	0	0
2025	4	6	0	13	9	27	0	0	0	0	0	0	0	53.78	0	0
2025	4	6	0	23	9	27	0	0	0	0	0	0	0	53.64	0	0
2025	4	6	0	33	9	27	0	0	0	0	0	0	0	53.49	0	0
2025	4	6	0	43	9	27	0	0	0	0	0	0	0	53.37	0	0
2025	4	6	0	53	9	27	0	0	0	0	0	0	0	53.24	0	0
2025	4	6	1	3	9	27	0	0	0	0	0	0	0	53.1	0	0
2025	4	6	1	13	9	27	0	0	0	0	0	0	0	52.97	0	0
2025	4	6	1	23	9	27	0	0	0	0	0	0	0	52.84	0	0
2025	4	6	1	33	9	27	0	0	0	0	0	0	0	52.72	0	0
2025	4	6	1	43	9	27	0	0	0	0	0	0	0	52.59	0	0
2025	4	6	1	53	9	28	0	0	0	0	0	0	0	52.48	0	0
2025	4	6	2	3	9	27	0	0	0	0	0	0	0	52.36	0	0
2025	4	6	2	13	9	27	0	0	0	0	0	0	0	52.25	0	0
2025	4	6	2	23	9	27	0	0	0	0	0	0	0	52.12	0	0
2025	4	6	2	33	9	27	0	0	0	0	0	0	0	52.02	0	0
2025	4	6	2	43	9	27	0	0	0	0	0	0	0	51.93	0	0
2025	4	6	2	53	9	27	0	0	0	0	0	0	0	51.82	0	0
2025	4	6	3	3	9	27	0	0	0	0	0	0	0	51.71	0	0
2025	4	6	3	13	9	27	0	0	0	0	0	0	0	51.62	0	0
2025	4	6	3	23	9	27	0	0	0	0	0	0	0	51.53	0	0
2025	4	6	3	33	9	27	0	0	0	0	0	0	0	51.44	0	0
2025	4	6	3	43	9	28	0	0	0	0	0	0	0	51.35	0	0
2025	4	6	3	53	9	27	0	0	0	0	0	0	0	51.26	0	0
2025	4	6	4	3	9	27	0	0	0	0	0	0	0	51.17	0	0
2025	4	6	4	13	9	28	0	0	0	0	0	0	0	51.08	0	0
2025	4	6	4	23	9	27	0	0	0	0	0	0	0	51.01	0	0
2025	4	6	4	33	9	27	0	0	0	0	0	0	0	50.92	0	0
2025	4	6	4	43	9	28	0	0	0	0	0	0	0	50.85	0	0
2025	4	6	4	53	9	28	0	0	0	0	0	0	0	50.77	0	0
2025	4	6	5	3	9	27	0	0	0	0	0	0	0	50.68	0	0
2025	4	6	5	13	9	27	0	0	0	0	0	0	0	50.61	0	0
2025	4	6	5	23	9	28	0	0	0	0	0	0	0	50.52	0	0
2025	4	6	5	33	9	27	0	0	0	0	0	0	0	50.45	0	0
2025	4	6	5	43	9	28	0	0	0	0	0	0	0	50.4	0	0
2025	4	6	5	53	9	27	0	0	0	0	0	0	0	50.32	0	0
2025	4	6	6	3	9	27	0	0	0	0	0	0	0	50.25	0	0
2025	4	6	6	13	9	27	0	0	0	0	0	0	0	50.18	0	0
2025	4	6	6	23	9	27	0	0	0	0	0	0	0	50.13	0	0
2025	4	6	6	33	9	27	0	0	0	0	0	0	0	50.07	0	0
2025	4	6	6	43	9	27	0	0	0	0	0	0	0	50.04	0	0
2025	4	6	6	53	9	28	0	0	0	0	0	0	0	50	0	0
2025	4	6	7	3	9	27	0	0	0	0	0	0	0	49.98	0	0
2025	4	6	7	13	9	27	0	0	0	0	0	0	0	49.96	0	0
2025	4	6	7	23	9	27	0	0	0	0	0	0	0	49.96	0	0
2025	4	6	7	33	9	28	0	0	0	0	0	0	0	49.98	0	0
2025	4	6	7	43	9	27	0	0	0	0	0	0	0	50	0	0
2025	4	6	7	53	9	27	0	0	0	0	0	0	0	50.04	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	6	8	3	9	28	0	0	0	0	0	0	0	50.11	0	0
2025	4	6	8	13	9	27	0	0	0	0	0	0	0	50.18	0	0
2025	4	6	8	23	9	27	0	0	0	0	0	0	0	50.25	0	0
2025	4	6	8	33	9	27	0	0	0	0	0	0	0	50.36	0	0
2025	4	6	8	43	9	27	0	0	0	0	0	0	0	50.49	0	0
2025	4	6	8	53	9	27	0	0	0	0	0	0	0	50.61	0	0
2025	4	6	9	3	9	27	0	0	0	0	0	0	0	50.76	0	0
2025	4	6	9	13	9	27	0	0	0	0	0	0	0	50.92	0	0
2025	4	6	9	23	9	27	0	0	0	0	0	0	0	51.08	0	0
2025	4	6	9	33	9	27	0	0	0	0	0	0	0	51.26	0	0
2025	4	6	9	43	9	27	0	0	0	0	0	0	0	51.44	0	0
2025	4	6	9	53	9	28	0	0	0	0	0	0	0	51.64	0	0
2025	4	6	10	3	9	27	0	0	0	0	0	0	0	51.85	0	0
2025	4	6	10	13	9	28	0	0	0	0	0	0	0	52.05	0	0
2025	4	6	10	23	9	28	0	0	0	0	0	0	0	52.27	0	0
2025	4	6	10	33	9	28	0	0	0	0	0	0	0	52.5	0	0
2025	4	6	10	43	9	27	0	0	0	0	0	0	0	52.74	0	0
2025	4	6	10	53	9	27	0	0	0	0	0	0	0	52.97	0	0
2025	4	6	11	3	9	27	0	0	0	0	0	0	0	53.22	0	0
2025	4	6	11	13	9	27	0	0	0	0	0	0	0	53.46	0	0
2025	4	6	11	23	9	28	0	0	0	0	0	0	0	53.71	0	0
2025	4	6	11	33	9	27	0	0	0	0	0	0	0	53.94	0	0
2025	4	6	11	43	9	27	0	0	0	0	0	0	0	54.21	0	0
2025	4	6	11	53	9	27	0	0	0	0	0	0	0	54.45	0	0
2025	4	6	12	3	9	28	0	0	0	0	0	0	0	54.7	0	0
2025	4	6	12	13	9	27	0	0	0	0	0	0	0	54.95	0	0
2025	4	6	12	23	9	27	0	0	0	0	0	0	0	55.2	0	0
2025	4	6	12	33	9	27	0	0	0	0	0	0	0	55.44	0	0
2025	4	6	12	43	9	27	0	0	0	0	0	0	0	55.69	0	0
2025	4	6	12	53	9	27	0	0	0	0	0	0	0	55.94	0	0
2025	4	6	13	3	9	27	0	0	0	0	0	0	0	56.17	0	0
2025	4	6	13	13	9	28	0	0	0	0	0	0	0	56.37	0	0
2025	4	6	13	23	9	27	0	0	0	0	0	0	0	56.62	0	0
2025	4	6	13	33	9	27	0	0	0	0	0	0	0	56.84	0	0
2025	4	6	13	43	9	27	0	0	0	0	0	0	0	57.04	0	0
2025	4	6	13	53	9	27	0	0	0	0	0	0	0	57.24	0	0
2025	4	6	14	3	9	27	0	0	0	0	0	0	0	57.43	0	0
2025	4	6	14	13	9	27	0	0	0	0	0	0	0	57.61	0	0
2025	4	6	14	23	9	27	0	0	0	0	0	0	0	57.78	0	0
2025	4	6	14	33	9	27	0	0	0	0	0	0	0	57.92	0	0
2025	4	6	14	43	9	27	0	0	0	0	0	0	0	58.05	0	0
2025	4	6	14	53	9	28	0	0	0	0	0	0	0	58.17	0	0
2025	4	6	15	3	9	26	0	0	0	0	0	0	0	58.33	0	0
2025	4	6	15	13	9	27	0	0	0	0	0	0	0	58.48	0	0
2025	4	6	15	23	9	27	0	0	0	0	0	0	0	58.59	0	0
2025	4	6	15	33	9	26	0	0	0	0	0	0	0	58.69	0	0
2025	4	6	15	43	9	26	0	0	0	0	0	0	0	58.78	0	0
2025	4	6	15	53	9	26	0	0	0	0	0	0	0	58.87	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	6	16	3	9	27	0	0	0	0	0	0	0	58.93	0	0
2025	4	6	16	13	9	27	0	0	0	0	0	0	0	58.96	0	0
2025	4	6	16	23	9	26	0	0	0	0	0	0	0	59.02	0	0
2025	4	6	16	33	9	26	0	0	0	0	0	0	0	59.07	0	0
2025	4	6	16	43	9	27	0	0	0	0	0	0	0	59.11	0	0
2025	4	6	16	53	9	26	0	0	0	0	0	0	0	59.13	0	0
2025	4	6	17	3	9	27	0	0	0	0	0	0	0	59.14	0	0
2025	4	6	17	13	9	26	0	0	0	0	0	0	0	59.14	0	0
2025	4	6	17	23	9	27	0	0	0	0	0	0	0	59.14	0	0
2025	4	6	17	33	9	27	0	0	0	0	0	0	0	59.14	0	0
2025	4	6	17	43	9	26	0	0	0	0	0	0	0	59.13	0	0
2025	4	6	17	53	9	27	0	0	0	0	0	0	0	59.11	0	0
2025	4	6	18	3	9	27	0	0	0	0	0	0	0	59.09	0	0
2025	4	6	18	13	9	26	0	0	0	0	0	0	0	59.05	0	0
2025	4	6	18	23	9	26	0	0	0	0	0	0	0	59.02	0	0
2025	4	6	18	33	9	26	0	0	0	0	0	0	0	58.96	0	0
2025	4	6	18	43	9	26	0	0	0	0	0	0	0	58.91	0	0
2025	4	6	18	53	9	26	0	0	0	0	0	0	0	58.86	0	0
2025	4	6	19	3	9	26	0	0	0	0	0	0	0	58.78	0	0
2025	4	6	19	13	9	27	0	0	0	0	0	0	0	58.71	0	0
2025	4	6	19	23	9	27	0	0	0	0	0	0	0	58.64	0	0
2025	4	6	19	33	9	26	0	0	0	0	0	0	0	58.55	0	0
2025	4	6	19	43	9	27	0	0	0	0	0	0	0	58.48	0	0
2025	4	6	19	53	9	26	0	0	0	0	0	0	0	58.39	0	0
2025	4	6	20	3	9	27	0	0	0	0	0	0	0	58.3	0	0
2025	4	6	20	13	9	27	0	0	0	0	0	0	0	58.21	0	0
2025	4	6	20	23	9	27	0	0	0	0	0	0	0	58.12	0	0
2025	4	6	20	33	9	27	0	0	0	0	0	0	0	58.01	0	0
2025	4	6	20	43	9	26	0	0	0	0	0	0	0	57.9	0	0
2025	4	6	20	53	9	27	0	0	0	0	0	0	0	57.79	0	0
2025	4	6	21	3	9	26	0	0	0	0	0	0	0	57.69	0	0
2025	4	6	21	13	9	27	0	0	0	0	0	0	0	57.58	0	0
2025	4	6	21	23	9	27	0	0	0	0	0	0	0	57.47	0	0
2025	4	6	21	33	9	26	0	0	0	0	0	0	0	57.36	0	0
2025	4	6	21	43	9	27	0	0	0	0	0	0	0	57.25	0	0
2025	4	6	21	53	9	26	0	0	0	0	0	0	0	57.15	0	0
2025	4	6	22	3	9	26	0	0	0	0	0	0	0	57.02	0	0
2025	4	6	22	13	9	27	0	0	0	0	0	0	0	56.91	0	0
2025	4	6	22	23	9	27	0	0	0	0	0	0	0	56.8	0	0
2025	4	6	22	33	9	26	0	0	0	0	0	0	0	56.68	0	0
2025	4	6	22	43	9	27	0	0	0	0	0	0	0	56.57	0	0
2025	4	6	22	53	9	27	0	0	0	0	0	0	0	56.44	0	0
2025	4	6	23	3	9	27	0	0	0	0	0	0	0	56.34	0	0
2025	4	6	23	13	9	27	0	0	0	0	0	0	0	56.21	0	0
2025	4	6	23	23	9	27	0	0	0	0	0	0	0	56.08	0	0
2025	4	6	23	33	9	27	0	0	0	0	0	0	0	55.96	0	0
2025	4	6	23	43	9	27	0	0	0	0	0	0	0	55.83	0	0
2025	4	6	23	53	9	27	0	0	0	0	0	0	0	55.71	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	7	0	3	9	27	0	0	0	0	0	0	0	55.6	0	0
2025	4	7	0	13	9	27	0	0	0	0	0	0	0	55.47	0	0
2025	4	7	0	23	9	27	0	0	0	0	0	0	0	55.35	0	0
2025	4	7	0	33	9	27	0	0	0	0	0	0	0	55.22	0	0
2025	4	7	0	43	9	27	0	0	0	0	0	0	0	55.09	0	0
2025	4	7	0	53	9	27	0	0	0	0	0	0	0	54.97	0	0
2025	4	7	1	3	9	27	0	0	0	0	0	0	0	54.86	0	0
2025	4	7	1	13	9	27	0	0	0	0	0	0	0	54.73	0	0
2025	4	7	1	23	9	27	0	0	0	0	0	0	0	54.63	0	0
2025	4	7	1	33	9	26	0	0	0	0	0	0	0	54.5	0	0
2025	4	7	1	43	9	27	0	0	0	0	0	0	0	54.39	0	0
2025	4	7	1	53	9	28	0	0	0	0	0	0	0	54.28	0	0
2025	4	7	2	3	9	27	0	0	0	0	0	0	0	54.16	0	0
2025	4	7	2	13	9	27	0	0	0	0	0	0	0	54.07	0	0
2025	4	7	2	23	9	27	0	0	0	0	0	0	0	53.96	0	0
2025	4	7	2	33	9	27	0	0	0	0	0	0	0	53.87	0	0
2025	4	7	2	43	9	27	0	0	0	0	0	0	0	53.76	0	0
2025	4	7	2	53	9	27	0	0	0	0	0	0	0	53.69	0	0
2025	4	7	3	3	9	27	0	0	0	0	0	0	0	53.6	0	0
2025	4	7	3	13	9	26	0	0	0	0	0	0	0	53.51	0	0
2025	4	7	3	23	9	27	0	0	0	0	0	0	0	53.44	0	0
2025	4	7	3	33	9	27	0	0	0	0	0	0	0	53.37	0	0
2025	4	7	3	43	9	27	0	0	0	0	0	0	0	53.29	0	0
2025	4	7	3	53	9	27	0	0	0	0	0	0	0	53.22	0	0
2025	4	7	4	3	9	26	0	0	0	0	0	0	0	53.15	0	0
2025	4	7	4	13	9	27	0	0	0	0	0	0	0	53.1	0	0
2025	4	7	4	23	9	26	0	0	0	0	0	0	0	53.02	0	0
2025	4	7	4	33	9	27	0	0	0	0	0	0	0	52.97	0	0
2025	4	7	4	43	9	27	0	0	0	0	0	0	0	52.93	0	0
2025	4	7	4	53	9	27	0	0	0	0	0	0	0	52.86	0	0
2025	4	7	5	3	9	27	0	0	0	0	0	0	0	52.83	0	0
2025	4	7	5	13	9	27	0	0	0	0	0	0	0	52.77	0	0
2025	4	7	5	23	9	27	0	0	0	0	0	0	0	52.74	0	0
2025	4	7	5	33	9	27	0	0	0	0	0	0	0	52.68	0	0
2025	4	7	5	43	9	27	0	0	0	0	0	0	0	52.65	0	0
2025	4	7	5	53	9	27	0	0	0	0	0	0	0	52.61	0	0
2025	4	7	6	3	9	26	0	0	0	0	0	0	0	52.57	0	0
2025	4	7	6	13	9	27	0	0	0	0	0	0	0	52.54	0	0
2025	4	7	6	23	9	27	0	0	0	0	0	0	0	52.52	0	0
2025	4	7	6	33	9	28	0	0	0	0	0	0	0	52.48	0	0
2025	4	7	6	43	9	27	0	0	0	0	0	0	0	52.48	0	0
2025	4	7	6	53	9	27	0	0	0	0	0	0	0	52.47	0	0
2025	4	7	7	3	9	27	0	0	0	0	0	0	0	52.47	0	0
2025	4	7	7	13	9	27	0	0	0	0	0	0	0	52.47	0	0
2025	4	7	7	23	9	27	0	0	0	0	0	0	0	52.47	0	0
2025	4	7	7	33	9	27	0	0	0	0	0	0	0	52.5	0	0
2025	4	7	7	43	9	27	0	0	0	0	0	0	0	52.54	0	0
2025	4	7	7	53	9	27	0	0	0	0	0	0	0	52.61	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	7	8	3	9	27	0	0	0	0	0	0	0	52.66	0	0
2025	4	7	8	13	9	26	0	0	0	0	0	0	0	52.75	0	0
2025	4	7	8	23	9	27	0	0	0	0	0	0	0	52.84	0	0
2025	4	7	8	33	9	27	0	0	0	0	0	0	0	52.95	0	0
2025	4	7	8	43	9	27	0	0	0	0	0	0	0	53.06	0	0
2025	4	7	8	53	9	28	0	0	0	0	0	0	0	53.2	0	0
2025	4	7	9	3	9	27	0	0	0	0	0	0	0	53.35	0	0
2025	4	7	9	13	9	27	0	0	0	0	0	0	0	53.51	0	0
2025	4	7	9	23	9	27	0	0	0	0	0	0	0	53.69	0	0
2025	4	7	9	33	9	27	0	0	0	0	0	0	0	53.85	0	0
2025	4	7	9	43	9	27	0	0	0	0	0	0	0	54	0	0
2025	4	7	9	53	9	27	0	0	0	0	0	0	0	54.12	0	0
2025	4	7	10	3	9	27	0	0	0	0	0	0	0	54.27	0	0
2025	4	7	10	13	9	27	0	0	0	0	0	0	0	54.37	0	0
2025	4	7	10	23	9	27	0	0	0	0	0	0	0	54.52	0	0
2025	4	7	10	33	9	27	0	0	0	0	0	0	0	54.64	0	0
2025	4	7	10	43	9	27	0	0	0	0	0	0	0	54.79	0	0
2025	4	7	10	53	9	27	0	0	0	0	0	0	0	54.91	0	0
2025	4	7	11	3	9	27	0	0	0	0	0	0	0	55.04	0	0
2025	4	7	11	13	9	27	0	0	0	0	0	0	0	55.18	0	0
2025	4	7	11	23	9	27	0	0	0	0	0	0	0	55.31	0	0
2025	4	7	11	33	9	27	0	0	0	0	0	0	0	55.44	0	0
2025	4	7	11	43	9	27	0	0	0	0	0	0	0	55.56	0	0
2025	4	7	11	53	9	27	0	0	0	0	0	0	0	55.69	0	0
2025	4	7	12	3	9	27	0	0	0	0	0	0	0	55.85	0	0
2025	4	7	12	13	9	27	0	0	0	0	0	0	0	55.99	0	0
2025	4	7	12	23	9	26	0	0	0	0	0	0	0	56.16	0	0
2025	4	7	12	33	9	27	0	0	0	0	0	0	0	56.34	0	0
2025	4	7	12	43	9	26	0	0	0	0	0	0	0	56.55	0	0
2025	4	7	12	53	9	28	0	0	0	0	0	0	0	56.77	0	0
2025	4	7	13	3	9	27	0	0	0	0	0	0	0	56.98	0	0
2025	4	7	13	13	9	26	0	0	0	0	0	0	0	57.22	0	0
2025	4	7	13	23	9	27	0	0	0	0	0	0	0	57.45	0	0
2025	4	7	13	33	9	27	0	0	0	0	0	0	0	57.7	0	0
2025	4	7	13	43	9	27	0	0	0	0	0	0	0	57.96	0	0
2025	4	7	13	53	9	27	0	0	0	0	0	0	0	58.19	0	0
2025	4	7	14	3	9	26	0	0	0	0	0	0	0	58.42	0	0
2025	4	7	14	13	9	26	0	0	0	0	0	0	0	58.66	0	0
2025	4	7	14	23	9	27	0	0	0	0	0	0	0	58.89	0	0
2025	4	7	14	33	9	27	0	0	0	0	0	0	0	59.11	0	0
2025	4	7	14	43	9	26	0	0	0	0	0	0	0	59.32	0	0
2025	4	7	14	53	9	27	0	0	0	0	0	0	0	59.5	0	0
2025	4	7	15	3	9	26	0	0	0	0	0	0	0	59.7	0	0
2025	4	7	15	13	9	27	0	0	0	0	0	0	0	59.86	0	0
2025	4	7	15	23	9	26	0	0	0	0	0	0	0	60.01	0	0
2025	4	7	15	33	9	27	0	0	0	0	0	0	0	60.13	0	0
2025	4	7	15	43	9	27	0	0	0	0	0	0	0	60.26	0	0
2025	4	7	15	53	9	26	0	0	0	0	0	0	0	60.37	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	7	16	3	9	26	0	0	0	0	0	0	0	60.44	0	0
2025	4	7	16	13	9	27	0	0	0	0	0	0	0	60.51	0	0
2025	4	7	16	23	9	27	0	0	0	0	0	0	0	60.57	0	0
2025	4	7	16	33	9	26	0	0	0	0	0	0	0	60.6	0	0
2025	4	7	16	43	9	27	0	0	0	0	0	0	0	60.64	0	0
2025	4	7	16	53	9	27	0	0	0	0	0	0	0	60.67	0	0
2025	4	7	17	3	9	26	0	0	0	0	0	0	0	60.67	0	0
2025	4	7	17	13	9	26	0	0	0	0	0	0	0	60.69	0	0
2025	4	7	17	23	9	26	0	0	0	0	0	0	0	60.67	0	0
2025	4	7	17	33	9	27	0	0	0	0	0	0	0	60.66	0	0
2025	4	7	17	43	9	26	0	0	0	0	0	0	0	60.62	0	0
2025	4	7	17	53	9	27	0	0	0	0	0	0	0	60.58	0	0
2025	4	7	18	3	9	27	0	0	0	0	0	0	0	60.55	0	0
2025	4	7	18	13	9	26	0	0	0	0	0	0	0	60.48	0	0
2025	4	7	18	23	9	27	0	0	0	0	0	0	0	60.4	0	0
2025	4	7	18	33	9	27	0	0	0	0	0	0	0	60.35	0	0
2025	4	7	18	43	9	26	0	0	0	0	0	0	0	60.28	0	0
2025	4	7	18	53	9	26	0	0	0	0	0	0	0	60.21	0	0
2025	4	7	19	3	9	26	0	0	0	0	0	0	0	60.12	0	0
2025	4	7	19	13	9	27	0	0	0	0	0	0	0	60.04	0	0
2025	4	7	19	23	9	26	0	0	0	0	0	0	0	59.97	0	0
2025	4	7	19	33	9	27	0	0	0	0	0	0	0	59.9	0	0
2025	4	7	19	43	9	26	0	0	0	0	0	0	0	59.85	0	0
2025	4	7	19	53	9	26	0	0	0	0	0	0	0	59.77	0	0
2025	4	7	20	3	9	26	0	0	0	0	0	0	0	59.7	0	0
2025	4	7	20	13	9	27	0	0	0	0	0	0	0	59.61	0	0
2025	4	7	20	23	9	27	0	0	0	0	0	0	0	59.52	0	0
2025	4	7	20	33	9	27	0	0	0	0	0	0	0	59.45	0	0
2025	4	7	20	43	9	26	0	0	0	0	0	0	0	59.38	0	0
2025	4	7	20	53	9	26	0	0	0	0	0	0	0	59.31	0	0
2025	4	7	21	3	9	27	0	0	0	0	0	0	0	59.22	0	0
2025	4	7	21	13	9	27	0	0	0	0	0	0	0	59.14	0	0
2025	4	7	21	23	9	27	0	0	0	0	0	0	0	59.07	0	0
2025	4	7	21	33	9	26	0	0	0	0	0	0	0	58.98	0	0
2025	4	7	21	43	9	26	0	0	0	0	0	0	0	58.89	0	0
2025	4	7	21	53	9	26	0	0	0	0	0	0	0	58.82	0	0
2025	4	7	22	3	9	26	0	0	0	0	0	0	0	58.73	0	0
2025	4	7	22	13	9	26	0	0	0	0	0	0	0	58.64	0	0
2025	4	7	22	23	9	26	0	0	0	0	0	0	0	58.55	0	0
2025	4	7	22	33	9	26	0	0	0	0	0	0	0	58.46	0	0
2025	4	7	22	43	9	27	0	0	0	0	0	0	0	58.37	0	0
2025	4	7	22	53	9	26	0	0	0	0	0	0	0	58.26	0	0
2025	4	7	23	3	9	26	0	0	0	0	0	0	0	58.17	0	0
2025	4	7	23	13	9	26	0	0	0	0	0	0	0	58.06	0	0
2025	4	7	23	23	9	27	0	0	0	0	0	0	0	57.96	0	0
2025	4	7	23	33	9	26	0	0	0	0	0	0	0	57.85	0	0
2025	4	7	23	43	9	27	0	0	0	0	0	0	0	57.74	0	0
2025	4	7	23	53	9	27	0	0	0	0	0	0	0	57.61	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	8	0	3	9	27	0	0	0	0	0	0	0	57.51	0	0
2025	4	8	0	13	9	26	0	0	0	0	0	0	0	57.38	0	0
2025	4	8	0	23	9	26	0	0	0	0	0	0	0	57.25	0	0
2025	4	8	0	33	9	26	0	0	0	0	0	0	0	57.13	0	0
2025	4	8	0	43	9	27	0	0	0	0	0	0	0	57.02	0	0
2025	4	8	0	53	9	26	0	0	0	0	0	0	0	56.88	0	0
2025	4	8	1	3	9	27	0	0	0	0	0	0	0	56.75	0	0
2025	4	8	1	13	9	26	0	0	0	0	0	0	0	56.64	0	0
2025	4	8	1	23	9	27	0	0	0	0	0	0	0	56.53	0	0
2025	4	8	1	33	9	27	0	0	0	0	0	0	0	56.43	0	0
2025	4	8	1	43	9	27	0	0	0	0	0	0	0	56.32	0	0
2025	4	8	1	53	9	27	0	0	0	0	0	0	0	56.21	0	0
2025	4	8	2	3	9	27	0	0	0	0	0	0	0	56.12	0	0
2025	4	8	2	13	9	27	0	0	0	0	0	0	0	56.03	0	0
2025	4	8	2	23	9	27	0	0	0	0	0	0	0	55.94	0	0
2025	4	8	2	33	9	27	0	0	0	0	0	0	0	55.85	0	0
2025	4	8	2	43	9	26	0	0	0	0	0	0	0	55.78	0	0
2025	4	8	2	53	9	27	0	0	0	0	0	0	0	55.69	0	0
2025	4	8	3	3	9	27	0	0	0	0	0	0	0	55.63	0	0
2025	4	8	3	13	9	27	0	0	0	0	0	0	0	55.56	0	0
2025	4	8	3	23	9	27	0	0	0	0	0	0	0	55.51	0	0
2025	4	8	3	33	9	27	0	0	0	0	0	0	0	55.44	0	0
2025	4	8	3	43	9	27	0	0	0	0	0	0	0	55.38	0	0
2025	4	8	3	53	9	27	0	0	0	0	0	0	0	55.31	0	0
2025	4	8	4	3	9	28	0	0	0	0	0	0	0	55.26	0	0
2025	4	8	4	13	9	27	0	0	0	0	0	0	0	55.18	0	0
2025	4	8	4	23	9	27	0	0	0	0	0	0	0	55.11	0	0
2025	4	8	4	33	9	27	0	0	0	0	0	0	0	55.04	0	0
2025	4	8	4	43	9	27	0	0	0	0	0	0	0	54.97	0	0
2025	4	8	4	53	9	27	0	0	0	0	0	0	0	54.9	0	0
2025	4	8	5	3	9	27	0	0	0	0	0	0	0	54.84	0	0
2025	4	8	5	13	9	27	0	0	0	0	0	0	0	54.77	0	0
2025	4	8	5	23	9	27	0	0	0	0	0	0	0	54.7	0	0
2025	4	8	5	33	9	28	0	0	0	0	0	0	0	54.63	0	0
2025	4	8	5	43	9	27	0	0	0	0	0	0	0	54.57	0	0
2025	4	8	5	53	9	26	0	0	0	0	0	0	0	54.5	0	0
2025	4	8	6	3	9	27	0	0	0	0	0	0	0	54.45	0	0
2025	4	8	6	13	9	28	0	0	0	0	0	0	0	54.39	0	0
2025	4	8	6	23	9	26	0	0	0	0	0	0	0	54.36	0	0
2025	4	8	6	33	9	27	0	0	0	0	0	0	0	54.3	0	0
2025	4	8	6	43	9	27	0	0	0	0	0	0	0	54.25	0	0
2025	4	8	6	53	9	27	0	0	0	0	0	0	0	54.21	0	0
2025	4	8	7	3	9	27	0	0	0	0	0	0	0	54.18	0	0
2025	4	8	7	13	9	27	0	0	0	0	0	0	0	54.16	0	0
2025	4	8	7	23	9	26	0	0	0	0	0	0	0	54.16	0	0
2025	4	8	7	33	9	27	0	0	0	0	0	0	0	54.16	0	0
2025	4	8	7	43	9	27	0	0	0	0	0	0	0	54.18	0	0
2025	4	8	7	53	9	27	0	0	0	0	0	0	0	54.23	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	8	8	3	9	26	0	0	0	0	0	0	0	54.28	0	0
2025	4	8	8	13	9	27	0	0	0	0	0	0	0	54.36	0	0
2025	4	8	8	23	9	27	0	0	0	0	0	0	0	54.45	0	0
2025	4	8	8	33	9	27	0	0	0	0	0	0	0	54.55	0	0
2025	4	8	8	43	9	28	0	0	0	0	0	0	0	54.66	0	0
2025	4	8	8	53	9	27	0	0	0	0	0	0	0	54.81	0	0
2025	4	8	9	3	9	28	0	0	0	0	0	0	0	54.95	0	0
2025	4	8	9	13	9	27	0	0	0	0	0	0	0	55.11	0	0
2025	4	8	9	23	9	27	0	0	0	0	0	0	0	55.29	0	0
2025	4	8	9	33	9	27	0	0	0	0	0	0	0	55.49	0	0
2025	4	8	9	43	9	27	0	0	0	0	0	0	0	55.69	0	0
2025	4	8	9	53	9	27	0	0	0	0	0	0	0	55.9	0	0
2025	4	8	10	3	9	27	0	0	0	0	0	0	0	56.1	0	0
2025	4	8	10	13	9	27	0	0	0	0	0	0	0	56.32	0	0
2025	4	8	10	23	9	27	0	0	0	0	0	0	0	56.55	0	0
2025	4	8	10	33	9	27	0	0	0	0	0	0	0	56.79	0	0
2025	4	8	10	43	9	27	0	0	0	0	0	0	0	57.02	0	0
2025	4	8	10	53	9	27	0	0	0	0	0	0	0	57.27	0	0
2025	4	8	11	3	9	27	0	0	0	0	0	0	0	57.49	0	0
2025	4	8	11	13	9	27	0	0	0	0	0	0	0	57.74	0	0
2025	4	8	11	23	9	28	0	0	0	0	0	0	0	57.97	0	0
2025	4	8	11	33	9	26	0	0	0	0	0	0	0	58.21	0	0
2025	4	8	11	43	9	27	0	0	0	0	0	0	0	58.46	0	0
2025	4	8	11	53	9	27	0	0	0	0	0	0	0	58.69	0	0
2025	4	8	12	3	9	27	0	0	0	0	0	0	0	58.93	0	0
2025	4	8	12	13	9	27	0	0	0	0	0	0	0	59.16	0	0
2025	4	8	12	23	9	27	0	0	0	0	0	0	0	59.4	0	0
2025	4	8	12	33	9	27	0	0	0	0	0	0	0	59.63	0	0
2025	4	8	12	43	9	26	0	0	0	0	0	0	0	59.86	0	0
2025	4	8	12	53	9	26	0	0	0	0	0	0	0	60.12	0	0
2025	4	8	13	3	9	26	0	0	0	0	0	0	0	60.33	0	0
2025	4	8	13	13	9	26	0	0	0	0	0	0	0	60.57	0	0
2025	4	8	13	23	9	26	0	0	0	0	0	0	0	60.76	0	0
2025	4	8	13	33	9	26	0	0	0	0	0	0	0	60.98	0	0
2025	4	8	13	43	9	26	0	0	0	0	0	0	0	61.21	0	0
2025	4	8	13	53	9	27	0	0	0	0	0	0	0	61.43	0	0
2025	4	8	14	3	9	26	0	0	0	0	0	0	0	61.61	0	0
2025	4	8	14	13	9	26	0	0	0	0	0	0	0	61.83	0	0
2025	4	8	14	23	9	27	0	0	0	0	0	0	0	62.01	0	0
2025	4	8	14	33	9	26	0	0	0	0	0	0	0	62.2	0	0
2025	4	8	14	43	9	26	0	0	0	0	0	0	0	62.37	0	0
2025	4	8	14	53	9	26	0	0	0	0	0	0	0	62.53	0	0
2025	4	8	15	3	9	26	0	0	0	0	0	0	0	62.65	0	0
2025	4	8	15	13	9	26	0	0	0	0	0	0	0	62.82	0	0
2025	4	8	15	23	9	26	0	0	0	0	0	0	0	62.94	0	0
2025	4	8	15	33	9	27	0	0	0	0	0	0	0	63.05	0	0
2025	4	8	15	43	9	26	0	0	0	0	0	0	0	63.16	0	0
2025	4	8	15	53	9	26	0	0	0	0	0	0	0	63.23	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	8	16	3	9	26	0	0	0	0	0	0	0	63.32	0	0
2025	4	8	16	13	9	26	0	0	0	0	0	0	0	63.37	0	0
2025	4	8	16	23	9	26	0	0	0	0	0	0	0	63.45	0	0
2025	4	8	16	33	9	26	0	0	0	0	0	0	0	63.46	0	0
2025	4	8	16	43	9	26	0	0	0	0	0	0	0	63.5	0	0
2025	4	8	16	53	9	26	0	0	0	0	0	0	0	63.52	0	0
2025	4	8	17	3	9	26	0	0	0	0	0	0	0	63.54	0	0
2025	4	8	17	13	9	26	0	0	0	0	0	0	0	63.52	0	0
2025	4	8	17	23	9	26	0	0	0	0	0	0	0	63.5	0	0
2025	4	8	17	33	9	26	0	0	0	0	0	0	0	63.48	0	0
2025	4	8	17	43	9	26	0	0	0	0	0	0	0	63.45	0	0
2025	4	8	17	53	9	26	0	0	0	0	0	0	0	63.39	0	0
2025	4	8	18	3	9	26	0	0	0	0	0	0	0	63.36	0	0
2025	4	8	18	13	9	26	0	0	0	0	0	0	0	63.28	0	0
2025	4	8	18	23	9	25	0	0	0	0	0	0	0	63.23	0	0
2025	4	8	18	33	9	25	0	0	0	0	0	0	0	63.16	0	0
2025	4	8	18	43	9	26	0	0	0	0	0	0	0	63.09	0	0
2025	4	8	18	53	9	27	0	0	0	0	0	0	0	63.01	0	0
2025	4	8	19	3	9	26	0	0	0	0	0	0	0	62.92	0	0
2025	4	8	19	13	9	26	0	0	0	0	0	0	0	62.85	0	0
2025	4	8	19	23	9	26	0	0	0	0	0	0	0	62.76	0	0
2025	4	8	19	33	9	25	0	0	0	0	0	0	0	62.67	0	0
2025	4	8	19	43	9	26	0	0	0	0	0	0	0	62.58	0	0
2025	4	8	19	53	9	26	0	0	0	0	0	0	0	62.49	0	0
2025	4	8	20	3	9	26	0	0	0	0	0	0	0	62.4	0	0
2025	4	8	20	13	9	26	0	0	0	0	0	0	0	62.29	0	0
2025	4	8	20	23	9	27	0	0	0	0	0	0	0	62.2	0	0
2025	4	8	20	33	9	26	0	0	0	0	0	0	0	62.1	0	0
2025	4	8	20	43	9	26	0	0	0	0	0	0	0	61.99	0	0
2025	4	8	20	53	9	26	0	0	0	0	0	0	0	61.9	0	0
2025	4	8	21	3	9	26	0	0	0	0	0	0	0	61.77	0	0
2025	4	8	21	13	9	26	0	0	0	0	0	0	0	61.66	0	0
2025	4	8	21	23	9	26	0	0	0	0	0	0	0	61.56	0	0
2025	4	8	21	33	9	26	0	0	0	0	0	0	0	61.45	0	0
2025	4	8	21	43	9	26	0	0	0	0	0	0	0	61.34	0	0
2025	4	8	21	53	9	26	0	0	0	0	0	0	0	61.23	0	0
2025	4	8	22	3	9	26	0	0	0	0	0	0	0	61.12	0	0
2025	4	8	22	13	9	27	0	0	0	0	0	0	0	61	0	0
2025	4	8	22	23	9	26	0	0	0	0	0	0	0	60.89	0	0
2025	4	8	22	33	9	26	0	0	0	0	0	0	0	60.76	0	0
2025	4	8	22	43	9	27	0	0	0	0	0	0	0	60.64	0	0
2025	4	8	22	53	9	27	0	0	0	0	0	0	0	60.51	0	0
2025	4	8	23	3	9	26	0	0	0	0	0	0	0	60.39	0	0
2025	4	8	23	13	9	27	0	0	0	0	0	0	0	60.28	0	0
2025	4	8	23	23	9	26	0	0	0	0	0	0	0	60.13	0	0
2025	4	8	23	33	9	26	0	0	0	0	0	0	0	60.01	0	0
2025	4	8	23	43	9	26	0	0	0	0	0	0	0	59.9	0	0
2025	4	8	23	53	9	26	0	0	0	0	0	0	0	59.76	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	9	8	3	9	27	0	0	0	0	0	0	0	56.23	0	0
2025	4	9	8	13	9	27	0	0	0	0	0	0	0	56.3	0	0
2025	4	9	8	23	9	27	0	0	0	0	0	0	0	56.41	0	0
2025	4	9	8	33	9	26	0	0	0	0	0	0	0	56.52	0	0
2025	4	9	8	43	9	26	0	0	0	0	0	0	0	56.64	0	0
2025	4	9	8	53	9	27	0	0	0	0	0	0	0	56.79	0	0
2025	4	9	9	3	9	26	0	0	0	0	0	0	0	56.93	0	0
2025	4	9	9	13	9	26	0	0	0	0	0	0	0	57.09	0	0
2025	4	9	9	23	9	27	0	0	0	0	0	0	0	57.25	0	0
2025	4	9	9	33	9	26	0	0	0	0	0	0	0	57.45	0	0
2025	4	9	9	43	9	27	0	0	0	0	0	0	0	57.63	0	0
2025	4	9	9	53	9	27	0	0	0	0	0	0	0	57.83	0	0
2025	4	9	10	3	9	26	0	0	0	0	0	0	0	58.05	0	0
2025	4	9	10	13	9	26	0	0	0	0	0	0	0	58.26	0	0
2025	4	9	10	23	9	27	0	0	0	0	0	0	0	58.48	0	0
2025	4	9	10	33	9	27	0	0	0	0	0	0	0	58.71	0	0
2025	4	9	10	43	9	27	0	0	0	0	0	0	0	58.95	0	0
2025	4	9	10	53	9	27	0	0	0	0	0	0	0	59.18	0	0
2025	4	9	11	3	9	27	0	0	0	0	0	0	0	59.43	0	0
2025	4	9	11	13	9	27	0	0	0	0	0	0	0	59.68	0	0
2025	4	9	11	23	9	27	0	0	0	0	0	0	0	59.92	0	0
2025	4	9	11	33	9	27	0	0	0	0	0	0	0	60.19	0	0
2025	4	9	11	43	9	27	0	0	0	0	0	0	0	60.44	0	0
2025	4	9	11	53	9	27	0	0	0	0	0	0	0	60.67	0	0
2025	4	9	12	3	9	26	0	0	0	0	0	0	0	60.94	0	0
2025	4	9	12	13	9	27	0	0	0	0	0	0	0	61.2	0	0
2025	4	9	12	23	9	27	0	0	0	0	0	0	0	61.43	0	0
2025	4	9	12	33	9	26	0	0	0	0	0	0	0	61.7	0	0
2025	4	9	12	43	9	26	0	0	0	0	0	0	0	61.95	0	0
2025	4	9	12	53	9	27	0	0	0	0	0	0	0	62.19	0	0
2025	4	9	13	3	9	27	0	0	0	0	0	0	0	62.44	0	0
2025	4	9	13	13	9	26	0	0	0	0	0	0	0	62.67	0	0
2025	4	9	13	23	9	26	0	0	0	0	0	0	0	62.89	0	0
2025	4	9	13	33	9	26	0	0	0	0	0	0	0	63.1	0	0
2025	4	9	13	43	9	26	0	0	0	0	0	0	0	63.3	0	0
2025	4	9	13	53	9	27	0	0	0	0	0	0	0	63.5	0	0
2025	4	9	14	3	9	26	0	0	0	0	0	0	0	63.7	0	0
2025	4	9	14	13	9	26	0	0	0	0	0	0	0	63.88	0	0
2025	4	9	14	23	9	25	0	0	0	0	0	0	0	64.06	0	0
2025	4	9	14	33	9	26	0	0	0	0	0	0	0	64.22	0	0
2025	4	9	14	43	9	26	0	0	0	0	0	0	0	64.38	0	0
2025	4	9	14	53	9	26	0	0	0	0	0	0	0	64.53	0	0
2025	4	9	15	3	9	26	0	0	0	0	0	0	0	64.65	0	0
2025	4	9	15	13	9	26	0	0	0	0	0	0	0	64.78	0	0
2025	4	9	15	23	9	26	0	0	0	0	0	0	0	64.89	0	0
2025	4	9	15	33	9	26	0	0	0	0	0	0	0	64.99	0	0
2025	4	9	15	43	9	26	0	0	0	0	0	0	0	65.08	0	0
2025	4	9	15	53	9	26	0	0	0	0	0	0	0	65.16	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	9	16	3	9	26	0	0	0	0	0	0	0	65.21	0	0
2025	4	9	16	13	9	26	0	0	0	0	0	0	0	65.26	0	0
2025	4	9	16	23	9	26	0	0	0	0	0	0	0	65.3	0	0
2025	4	9	16	33	9	25	0	0	0	0	0	0	0	65.34	0	0
2025	4	9	16	43	9	27	0	0	0	0	0	0	0	65.34	0	0
2025	4	9	16	53	9	26	0	0	0	0	0	0	0	65.35	0	0
2025	4	9	17	3	9	26	0	0	0	0	0	0	0	65.34	0	0
2025	4	9	17	13	9	26	0	0	0	0	0	0	0	65.32	0	0
2025	4	9	17	23	9	26	0	0	0	0	0	0	0	65.28	0	0
2025	4	9	17	33	9	26	0	0	0	0	0	0	0	65.25	0	0
2025	4	9	17	43	9	26	0	0	0	0	0	0	0	65.19	0	0
2025	4	9	17	53	9	26	0	0	0	0	0	0	0	65.16	0	0
2025	4	9	18	3	9	25	0	0	0	0	0	0	0	65.1	0	0
2025	4	9	18	13	9	26	0	0	0	0	0	0	0	65.05	0	0
2025	4	9	18	23	9	26	0	0	0	0	0	0	0	64.98	0	0
2025	4	9	18	33	9	26	0	0	0	0	0	0	0	64.9	0	0
2025	4	9	18	43	9	26	0	0	0	0	0	0	0	64.81	0	0
2025	4	9	18	53	9	26	0	0	0	0	0	0	0	64.72	0	0
2025	4	9	19	3	9	26	0	0	0	0	0	0	0	64.65	0	0
2025	4	9	19	13	9	26	0	0	0	0	0	0	0	64.56	0	0
2025	4	9	19	23	9	26	0	0	0	0	0	0	0	64.49	0	0
2025	4	9	19	33	9	26	0	0	0	0	0	0	0	64.4	0	0
2025	4	9	19	43	9	26	0	0	0	0	0	0	0	64.33	0	0
2025	4	9	19	53	9	25	0	0	0	0	0	0	0	64.24	0	0
2025	4	9	20	3	9	25	0	0	0	0	0	0	0	64.15	0	0
2025	4	9	20	13	9	26	0	0	0	0	0	0	0	64.06	0	0
2025	4	9	20	23	9	26	0	0	0	0	0	0	0	63.97	0	0
2025	4	9	20	33	9	26	0	0	0	0	0	0	0	63.88	0	0
2025	4	9	20	43	9	26	0	0	0	0	0	0	0	63.79	0	0
2025	4	9	20	53	9	26	0	0	0	0	0	0	0	63.68	0	0
2025	4	9	21	3	9	26	0	0	0	0	0	0	0	63.59	0	0
2025	4	9	21	13	9	26	0	0	0	0	0	0	0	63.5	0	0
2025	4	9	21	23	9	26	0	0	0	0	0	0	0	63.41	0	0
2025	4	9	21	33	9	27	0	0	0	0	0	0	0	63.28	0	0
2025	4	9	21	43	9	26	0	0	0	0	0	0	0	63.19	0	0
2025	4	9	21	53	9	26	0	0	0	0	0	0	0	63.09	0	0
2025	4	9	22	3	9	26	0	0	0	0	0	0	0	62.98	0	0
2025	4	9	22	13	9	26	0	0	0	0	0	0	0	62.87	0	0
2025	4	9	22	23	9	25	0	0	0	0	0	0	0	62.78	0	0
2025	4	9	22	33	9	26	0	0	0	0	0	0	0	62.65	0	0
2025	4	9	22	43	9	26	0	0	0	0	0	0	0	62.55	0	0
2025	4	9	22	53	9	26	0	0	0	0	0	0	0	62.44	0	0
2025	4	9	23	3	9	26	0	0	0	0	0	0	0	62.31	0	0
2025	4	9	23	13	9	26	0	0	0	0	0	0	0	62.2	0	0
2025	4	9	23	23	9	26	0	0	0	0	0	0	0	62.08	0	0
2025	4	9	23	33	9	26	0	0	0	0	0	0	0	61.97	0	0
2025	4	9	23	43	9	26	0	0	0	0	0	0	0	61.86	0	0
2025	4	9	23	53	9	26	0	0	0	0	0	0	0	61.75	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	10	0	3	9	26	0	0	0	0	0	0	0	61.65	0	0
2025	4	10	0	13	9	26	0	0	0	0	0	0	0	61.56	0	0
2025	4	10	0	23	9	26	0	0	0	0	0	0	0	61.45	0	0
2025	4	10	0	33	9	27	0	0	0	0	0	0	0	61.36	0	0
2025	4	10	0	43	9	26	0	0	0	0	0	0	0	61.25	0	0
2025	4	10	0	53	9	26	0	0	0	0	0	0	0	61.18	0	0
2025	4	10	1	3	9	26	0	0	0	0	0	0	0	61.07	0	0
2025	4	10	1	13	9	26	0	0	0	0	0	0	0	60.98	0	0
2025	4	10	1	23	9	26	0	0	0	0	0	0	0	60.89	0	0
2025	4	10	1	33	9	26	0	0	0	0	0	0	0	60.8	0	0
2025	4	10	1	43	9	27	0	0	0	0	0	0	0	60.69	0	0
2025	4	10	1	53	9	27	0	0	0	0	0	0	0	60.62	0	0
2025	4	10	2	3	9	26	0	0	0	0	0	0	0	60.53	0	0
2025	4	10	2	13	9	26	0	0	0	0	0	0	0	60.46	0	0
2025	4	10	2	23	9	27	0	0	0	0	0	0	0	60.39	0	0
2025	4	10	2	33	9	26	0	0	0	0	0	0	0	60.31	0	0
2025	4	10	2	43	9	26	0	0	0	0	0	0	0	60.24	0	0
2025	4	10	2	53	9	27	0	0	0	0	0	0	0	60.15	0	0
2025	4	10	3	3	9	26	0	0	0	0	0	0	0	60.08	0	0
2025	4	10	3	13	9	27	0	0	0	0	0	0	0	60.01	0	0
2025	4	10	3	23	9	26	0	0	0	0	0	0	0	59.94	0	0
2025	4	10	3	33	9	26	0	0	0	0	0	0	0	59.86	0	0
2025	4	10	3	43	9	27	0	0	0	0	0	0	0	59.79	0	0
2025	4	10	3	53	9	27	0	0	0	0	0	0	0	59.72	0	0
2025	4	10	4	3	9	27	0	0	0	0	0	0	0	59.65	0	0
2025	4	10	4	13	9	27	0	0	0	0	0	0	0	59.58	0	0
2025	4	10	4	23	9	26	0	0	0	0	0	0	0	59.52	0	0
2025	4	10	4	33	9	26	0	0	0	0	0	0	0	59.43	0	0
2025	4	10	4	43	9	26	0	0	0	0	0	0	0	59.36	0	0
2025	4	10	4	53	9	27	0	0	0	0	0	0	0	59.31	0	0
2025	4	10	5	3	9	26	0	0	0	0	0	0	0	59.22	0	0
2025	4	10	5	13	9	26	0	0	0	0	0	0	0	59.16	0	0
2025	4	10	5	23	9	27	0	0	0	0	0	0	0	59.09	0	0
2025	4	10	5	33	9	26	0	0	0	0	0	0	0	59.04	0	0
2025	4	10	5	43	9	26	0	0	0	0	0	0	0	58.98	0	0
2025	4	10	5	53	9	26	0	0	0	0	0	0	0	58.91	0	0
2025	4	10	6	3	9	26	0	0	0	0	0	0	0	58.84	0	0
2025	4	10	6	13	9	26	0	0	0	0	0	0	0	58.8	0	0
2025	4	10	6	23	9	27	0	0	0	0	0	0	0	58.73	0	0
2025	4	10	6	33	9	26	0	0	0	0	0	0	0	58.69	0	0
2025	4	10	6	43	9	27	0	0	0	0	0	0	0	58.66	0	0
2025	4	10	6	53	9	26	0	0	0	0	0	0	0	58.62	0	0
2025	4	10	7	3	9	26	0	0	0	0	0	0	0	58.6	0	0
2025	4	10	7	13	9	26	0	0	0	0	0	0	0	58.62	0	0
2025	4	10	7	23	9	27	0	0	0	0	0	0	0	58.64	0	0
2025	4	10	7	33	9	26	0	0	0	0	0	0	0	58.66	0	0
2025	4	10	7	43	9	27	0	0	0	0	0	0	0	58.69	0	0
2025	4	10	7	53	9	27	0	0	0	0	0	0	0	58.77	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	10	8	3	9	27	0	0	0	0	0	0	0	58.82	0	0
2025	4	10	8	13	9	27	0	0	0	0	0	0	0	58.91	0	0
2025	4	10	8	23	9	26	0	0	0	0	0	0	0	59	0	0
2025	4	10	8	33	9	26	0	0	0	0	0	0	0	59.11	0	0
2025	4	10	8	43	9	27	0	0	0	0	0	0	0	59.23	0	0
2025	4	10	8	53	9	26	0	0	0	0	0	0	0	59.36	0	0
2025	4	10	9	3	9	27	0	0	0	0	0	0	0	59.5	0	0
2025	4	10	9	13	9	26	0	0	0	0	0	0	0	59.67	0	0
2025	4	10	9	23	9	27	0	0	0	0	0	0	0	59.81	0	0
2025	4	10	9	33	9	26	0	0	0	0	0	0	0	59.99	0	0
2025	4	10	9	43	9	27	0	0	0	0	0	0	0	60.17	0	0
2025	4	10	9	53	9	27	0	0	0	0	0	0	0	60.35	0	0
2025	4	10	10	3	9	27	0	0	0	0	0	0	0	60.53	0	0
2025	4	10	10	13	9	26	0	0	0	0	0	0	0	60.73	0	0
2025	4	10	10	23	9	26	0	0	0	0	0	0	0	60.93	0	0
2025	4	10	10	33	9	27	0	0	0	0	0	0	0	61.12	0	0
2025	4	10	10	43	9	26	0	0	0	0	0	0	0	61.34	0	0
2025	4	10	10	53	9	26	0	0	0	0	0	0	0	61.54	0	0
2025	4	10	11	3	9	27	0	0	0	0	0	0	0	61.75	0	0
2025	4	10	11	13	9	26	0	0	0	0	0	0	0	61.95	0	0
2025	4	10	11	23	9	27	0	0	0	0	0	0	0	62.15	0	0
2025	4	10	11	33	9	27	0	0	0	0	0	0	0	62.35	0	0
2025	4	10	11	43	9	26	0	0	0	0	0	0	0	62.55	0	0
2025	4	10	11	53	9	26	0	0	0	0	0	0	0	62.76	0	0
2025	4	10	12	3	9	27	0	0	0	0	0	0	0	62.96	0	0
2025	4	10	12	13	9	25	0	0	0	0	0	0	0	63.18	0	0
2025	4	10	12	23	9	26	0	0	0	0	0	0	0	63.39	0	0
2025	4	10	12	33	9	26	0	0	0	0	0	0	0	63.57	0	0
2025	4	10	12	43	9	26	0	0	0	0	0	0	0	63.79	0	0
2025	4	10	12	53	9	26	0	0	0	0	0	0	0	63.97	0	0
2025	4	10	13	3	9	26	0	0	0	0	0	0	0	64.15	0	0
2025	4	10	13	13	9	26	0	0	0	0	0	0	0	64.36	0	0
2025	4	10	13	23	9	26	0	0	0	0	0	0	0	64.54	0	0
2025	4	10	13	33	9	26	0	0	0	0	0	0	0	64.71	0	0
2025	4	10	13	43	9	26	0	0	0	0	0	0	0	64.89	0	0
2025	4	10	13	53	9	26	0	0	0	0	0	0	0	65.05	0	0
2025	4	10	14	3	9	26	0	0	0	0	0	0	0	65.23	0	0
2025	4	10	14	13	9	26	0	0	0	0	0	0	0	65.37	0	0
2025	4	10	14	23	9	25	0	0	0	0	0	0	0	65.52	0	0
2025	4	10	14	33	9	25	0	0	0	0	0	0	0	65.64	0	0
2025	4	10	14	43	9	25	0	0	0	0	0	0	0	65.77	0	0
2025	4	10	14	53	9	26	0	0	0	0	0	0	0	65.88	0	0
2025	4	10	15	3	9	25	0	0	0	0	0	0	0	65.98	0	0
2025	4	10	15	13	9	26	0	0	0	0	0	0	0	66.09	0	0
2025	4	10	15	23	9	26	0	0	0	0	0	0	0	66.16	0	0
2025	4	10	15	33	9	26	0	0	0	0	0	0	0	66.24	0	0
2025	4	10	15	43	9	26	0	0	0	0	0	0	0	66.31	0	0
2025	4	10	15	53	9	25	0	0	0	0	0	0	0	66.36	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	11	0	3	9	27	0	0	0	0	0	0	0	62.58	0	0
2025	4	11	0	13	9	26	0	0	0	0	0	0	0	62.47	0	0
2025	4	11	0	23	9	26	0	0	0	0	0	0	0	62.37	0	0
2025	4	11	0	33	9	26	0	0	0	0	0	0	0	62.28	0	0
2025	4	11	0	43	9	26	0	0	0	0	0	0	0	62.19	0	0
2025	4	11	0	53	9	26	0	0	0	0	0	0	0	62.1	0	0
2025	4	11	1	3	9	26	0	0	0	0	0	0	0	61.99	0	0
2025	4	11	1	13	9	26	0	0	0	0	0	0	0	61.9	0	0
2025	4	11	1	23	9	26	0	0	0	0	0	0	0	61.79	0	0
2025	4	11	1	33	9	26	0	0	0	0	0	0	0	61.7	0	0
2025	4	11	1	43	9	26	0	0	0	0	0	0	0	61.61	0	0
2025	4	11	1	53	9	26	0	0	0	0	0	0	0	61.54	0	0
2025	4	11	2	3	9	26	0	0	0	0	0	0	0	61.47	0	0
2025	4	11	2	13	9	26	0	0	0	0	0	0	0	61.38	0	0
2025	4	11	2	23	9	27	0	0	0	0	0	0	0	61.29	0	0
2025	4	11	2	33	9	26	0	0	0	0	0	0	0	61.23	0	0
2025	4	11	2	43	9	27	0	0	0	0	0	0	0	61.16	0	0
2025	4	11	2	53	9	26	0	0	0	0	0	0	0	61.07	0	0
2025	4	11	3	3	9	26	0	0	0	0	0	0	0	61.02	0	0
2025	4	11	3	13	9	26	0	0	0	0	0	0	0	60.96	0	0
2025	4	11	3	23	9	26	0	0	0	0	0	0	0	60.87	0	0
2025	4	11	3	33	9	26	0	0	0	0	0	0	0	60.8	0	0
2025	4	11	3	43	9	26	0	0	0	0	0	0	0	60.73	0	0
2025	4	11	3	53	9	26	0	0	0	0	0	0	0	60.66	0	0
2025	4	11	4	3	9	26	0	0	0	0	0	0	0	60.58	0	0
2025	4	11	4	13	9	27	0	0	0	0	0	0	0	60.51	0	0
2025	4	11	4	23	9	27	0	0	0	0	0	0	0	60.46	0	0
2025	4	11	4	33	9	27	0	0	0	0	0	0	0	60.39	0	0
2025	4	11	4	43	9	27	0	0	0	0	0	0	0	60.31	0	0
2025	4	11	4	53	9	26	0	0	0	0	0	0	0	60.26	0	0
2025	4	11	5	3	9	27	0	0	0	0	0	0	0	60.19	0	0
2025	4	11	5	13	9	26	0	0	0	0	0	0	0	60.12	0	0
2025	4	11	5	23	9	26	0	0	0	0	0	0	0	60.04	0	0
2025	4	11	5	33	9	27	0	0	0	0	0	0	0	59.99	0	0
2025	4	11	5	43	9	27	0	0	0	0	0	0	0	59.94	0	0
2025	4	11	5	53	9	26	0	0	0	0	0	0	0	59.88	0	0
2025	4	11	6	3	9	27	0	0	0	0	0	0	0	59.81	0	0
2025	4	11	6	13	9	27	0	0	0	0	0	0	0	59.76	0	0
2025	4	11	6	23	9	27	0	0	0	0	0	0	0	59.7	0	0
2025	4	11	6	33	9	26	0	0	0	0	0	0	0	59.67	0	0
2025	4	11	6	43	9	26	0	0	0	0	0	0	0	59.63	0	0
2025	4	11	6	53	9	26	0	0	0	0	0	0	0	59.61	0	0
2025	4	11	7	3	9	27	0	0	0	0	0	0	0	59.61	0	0
2025	4	11	7	13	9	26	0	0	0	0	0	0	0	59.61	0	0
2025	4	11	7	23	9	26	0	0	0	0	0	0	0	59.63	0	0
2025	4	11	7	33	9	27	0	0	0	0	0	0	0	59.65	0	0
2025	4	11	7	43	9	27	0	0	0	0	0	0	0	59.68	0	0
2025	4	11	7	53	9	27	0	0	0	0	0	0	0	59.72	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	11	8	3	9	27	0	0	0	0	0	0	0	59.79	0	0
2025	4	11	8	13	9	26	0	0	0	0	0	0	0	59.88	0	0
2025	4	11	8	23	9	26	0	0	0	0	0	0	0	59.99	0	0
2025	4	11	8	33	9	26	0	0	0	0	0	0	0	60.12	0	0
2025	4	11	8	43	9	27	0	0	0	0	0	0	0	60.24	0	0
2025	4	11	8	53	9	26	0	0	0	0	0	0	0	60.39	0	0
2025	4	11	9	3	9	26	0	0	0	0	0	0	0	60.49	0	0
2025	4	11	9	13	9	26	0	0	0	0	0	0	0	60.62	0	0
2025	4	11	9	23	9	27	0	0	0	0	0	0	0	60.78	0	0
2025	4	11	9	33	9	27	0	0	0	0	0	0	0	60.96	0	0
2025	4	11	9	43	9	27	0	0	0	0	0	0	0	61.14	0	0
2025	4	11	9	53	9	26	0	0	0	0	0	0	0	61.32	0	0
2025	4	11	10	3	9	26	0	0	0	0	0	0	0	61.52	0	0
2025	4	11	10	13	9	26	0	0	0	0	0	0	0	61.7	0	0
2025	4	11	10	23	9	26	0	0	0	0	0	0	0	61.9	0	0
2025	4	11	10	33	9	26	0	0	0	0	0	0	0	62.08	0	0
2025	4	11	10	43	9	26	0	0	0	0	0	0	0	62.29	0	0
2025	4	11	10	53	9	26	0	0	0	0	0	0	0	62.51	0	0
2025	4	11	11	3	9	26	0	0	0	0	0	0	0	62.73	0	0
2025	4	11	11	13	9	26	0	0	0	0	0	0	0	62.94	0	0
2025	4	11	11	23	9	26	0	0	0	0	0	0	0	63.16	0	0
2025	4	11	11	33	9	26	0	0	0	0	0	0	0	63.37	0	0
2025	4	11	11	43	9	26	0	0	0	0	0	0	0	63.59	0	0
2025	4	11	11	53	9	27	0	0	0	0	0	0	0	63.79	0	0
2025	4	11	12	3	9	26	0	0	0	0	0	0	0	63.97	0	0
2025	4	11	12	13	9	26	0	0	0	0	0	0	0	64.18	0	0
2025	4	11	12	23	9	26	0	0	0	0	0	0	0	64.4	0	0
2025	4	11	12	33	9	27	0	0	0	0	0	0	0	64.6	0	0
2025	4	11	12	43	9	26	0	0	0	0	0	0	0	64.8	0	0
2025	4	11	12	53	9	25	0	0	0	0	0	0	0	64.99	0	0
2025	4	11	13	3	9	26	0	0	0	0	0	0	0	65.19	0	0
2025	4	11	13	13	9	25	0	0	0	0	0	0	0	65.35	0	0
2025	4	11	13	23	9	26	0	0	0	0	0	0	0	65.53	0	0
2025	4	11	13	33	9	25	0	0	0	0	0	0	0	65.7	0	0
2025	4	11	13	43	9	26	0	0	0	0	0	0	0	65.86	0	0
2025	4	11	13	53	9	26	0	0	0	0	0	0	0	66.02	0	0
2025	4	11	14	3	9	25	0	0	0	0	0	0	0	66.16	0	0
2025	4	11	14	13	9	26	0	0	0	0	0	0	0	66.31	0	0
2025	4	11	14	23	9	26	0	0	0	0	0	0	0	66.45	0	0
2025	4	11	14	33	9	26	0	0	0	0	0	0	0	66.56	0	0
2025	4	11	14	43	9	26	0	0	0	0	0	0	0	66.67	0	0
2025	4	11	14	53	9	26	0	0	0	0	0	0	0	66.76	0	0
2025	4	11	15	3	9	26	0	0	0	0	0	0	0	66.87	0	0
2025	4	11	15	13	9	25	0	0	0	0	0	0	0	66.96	0	0
2025	4	11	15	23	9	26	0	0	0	0	0	0	0	67.01	0	0
2025	4	11	15	33	9	26	0	0	0	0	0	0	0	67.08	0	0
2025	4	11	15	43	9	26	0	0	0	0	0	0	0	67.15	0	0
2025	4	11	15	53	9	26	0	0	0	0	0	0	0	67.19	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	11	16	3	9	26	0	0	0	0	0	0	0	67.24	0	0
2025	4	11	16	13	9	26	0	0	0	0	0	0	0	67.26	0	0
2025	4	11	16	23	9	26	0	0	0	0	0	0	0	67.26	0	0
2025	4	11	16	33	9	26	0	0	0	0	0	0	0	67.28	0	0
2025	4	11	16	43	9	25	0	0	0	0	0	0	0	67.28	0	0
2025	4	11	16	53	9	25	0	0	0	0	0	0	0	67.24	0	0
2025	4	11	17	3	9	26	0	0	0	0	0	0	0	67.21	0	0
2025	4	11	17	13	9	26	0	0	0	0	0	0	0	67.19	0	0
2025	4	11	17	23	9	26	0	0	0	0	0	0	0	67.12	0	0
2025	4	11	17	33	9	26	0	0	0	0	0	0	0	67.05	0	0
2025	4	11	17	43	9	25	0	0	0	0	0	0	0	66.97	0	0
2025	4	11	17	53	9	25	0	0	0	0	0	0	0	66.9	0	0
2025	4	11	18	3	9	26	0	0	0	0	0	0	0	66.83	0	0
2025	4	11	18	13	9	26	0	0	0	0	0	0	0	66.74	0	0
2025	4	11	18	23	9	26	0	0	0	0	0	0	0	66.67	0	0
2025	4	11	18	33	9	26	0	0	0	0	0	0	0	66.58	0	0
2025	4	11	18	43	9	26	0	0	0	0	0	0	0	66.49	0	0
2025	4	11	18	53	9	26	0	0	0	0	0	0	0	66.4	0	0
2025	4	11	19	3	9	26	0	0	0	0	0	0	0	66.29	0	0
2025	4	11	19	13	9	26	0	0	0	0	0	0	0	66.2	0	0
2025	4	11	19	23	9	26	0	0	0	0	0	0	0	66.11	0	0
2025	4	11	19	33	9	26	0	0	0	0	0	0	0	66.04	0	0
2025	4	11	19	43	9	26	0	0	0	0	0	0	0	65.95	0	0
2025	4	11	19	53	9	26	0	0	0	0	0	0	0	65.88	0	0
2025	4	11	20	3	9	26	0	0	0	0	0	0	0	65.77	0	0
2025	4	11	20	13	9	26	0	0	0	0	0	0	0	65.68	0	0
2025	4	11	20	23	9	26	0	0	0	0	0	0	0	65.59	0	0
2025	4	11	20	33	9	26	0	0	0	0	0	0	0	65.5	0	0
2025	4	11	20	43	9	26	0	0	0	0	0	0	0	65.39	0	0
2025	4	11	20	53	9	26	0	0	0	0	0	0	0	65.3	0	0
2025	4	11	21	3	9	26	0	0	0	0	0	0	0	65.19	0	0
2025	4	11	21	13	9	25	0	0	0	0	0	0	0	65.08	0	0
2025	4	11	21	23	9	26	0	0	0	0	0	0	0	64.98	0	0
2025	4	11	21	33	9	26	0	0	0	0	0	0	0	64.87	0	0
2025	4	11	21	43	9	26	0	0	0	0	0	0	0	64.74	0	0
2025	4	11	21	53	9	25	0	0	0	0	0	0	0	64.63	0	0
2025	4	11	22	3	9	26	0	0	0	0	0	0	0	64.53	0	0
2025	4	11	22	13	9	26	0	0	0	0	0	0	0	64.4	0	0
2025	4	11	22	23	9	26	0	0	0	0	0	0	0	64.29	0	0
2025	4	11	22	33	9	26	0	0	0	0	0	0	0	64.18	0	0
2025	4	11	22	43	9	26	0	0	0	0	0	0	0	64.06	0	0
2025	4	11	22	53	9	26	0	0	0	0	0	0	0	63.95	0	0
2025	4	11	23	3	9	26	0	0	0	0	0	0	0	63.82	0	0
2025	4	11	23	13	9	26	0	0	0	0	0	0	0	63.72	0	0
2025	4	11	23	23	9	27	0	0	0	0	0	0	0	63.61	0	0
2025	4	11	23	33	9	26	0	0	0	0	0	0	0	63.48	0	0
2025	4	11	23	43	9	26	0	0	0	0	0	0	0	63.37	0	0
2025	4	11	23	53	9	26	0	0	0	0	0	0	0	63.25	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	12	0	3	9	25	0	0	0	0	0	0	0	63.14	0	0
2025	4	12	0	13	9	26	0	0	0	0	0	0	0	63.01	0	0
2025	4	12	0	23	9	26	0	0	0	0	0	0	0	62.89	0	0
2025	4	12	0	33	9	26	0	0	0	0	0	0	0	62.78	0	0
2025	4	12	0	43	9	25	0	0	0	0	0	0	0	62.67	0	0
2025	4	12	0	53	9	26	0	0	0	0	0	0	0	62.55	0	0
2025	4	12	1	3	9	26	0	0	0	0	0	0	0	62.44	0	0
2025	4	12	1	13	9	26	0	0	0	0	0	0	0	62.31	0	0
2025	4	12	1	23	9	26	0	0	0	0	0	0	0	62.2	0	0
2025	4	12	1	33	9	26	0	0	0	0	0	0	0	62.1	0	0
2025	4	12	1	43	9	26	0	0	0	0	0	0	0	61.99	0	0
2025	4	12	1	53	9	27	0	0	0	0	0	0	0	61.9	0	0
2025	4	12	2	3	9	26	0	0	0	0	0	0	0	61.81	0	0
2025	4	12	2	13	9	26	0	0	0	0	0	0	0	61.7	0	0
2025	4	12	2	23	9	26	0	0	0	0	0	0	0	61.59	0	0
2025	4	12	2	33	9	26	0	0	0	0	0	0	0	61.5	0	0
2025	4	12	2	43	9	26	0	0	0	0	0	0	0	61.43	0	0
2025	4	12	2	53	9	26	0	0	0	0	0	0	0	61.34	0	0
2025	4	12	3	3	9	26	0	0	0	0	0	0	0	61.25	0	0
2025	4	12	3	13	9	26	0	0	0	0	0	0	0	61.16	0	0
2025	4	12	3	23	9	26	0	0	0	0	0	0	0	61.07	0	0
2025	4	12	3	33	9	27	0	0	0	0	0	0	0	61	0	0
2025	4	12	3	43	9	27	0	0	0	0	0	0	0	60.91	0	0
2025	4	12	3	53	9	26	0	0	0	0	0	0	0	60.82	0	0
2025	4	12	4	3	9	26	0	0	0	0	0	0	0	60.75	0	0
2025	4	12	4	13	9	27	0	0	0	0	0	0	0	60.66	0	0
2025	4	12	4	23	9	26	0	0	0	0	0	0	0	60.58	0	0
2025	4	12	4	33	9	26	0	0	0	0	0	0	0	60.49	0	0
2025	4	12	4	43	9	27	0	0	0	0	0	0	0	60.42	0	0
2025	4	12	4	53	9	27	0	0	0	0	0	0	0	60.33	0	0
2025	4	12	5	3	9	26	0	0	0	0	0	0	0	60.24	0	0
2025	4	12	5	13	9	26	0	0	0	0	0	0	0	60.17	0	0
2025	4	12	5	23	9	26	0	0	0	0	0	0	0	60.1	0	0
2025	4	12	5	33	9	26	0	0	0	0	0	0	0	60.01	0	0
2025	4	12	5	43	9	27	0	0	0	0	0	0	0	59.94	0	0
2025	4	12	5	53	9	27	0	0	0	0	0	0	0	59.85	0	0
2025	4	12	6	3	9	26	0	0	0	0	0	0	0	59.77	0	0
2025	4	12	6	13	9	26	0	0	0	0	0	0	0	59.7	0	0
2025	4	12	6	23	9	27	0	0	0	0	0	0	0	59.63	0	0
2025	4	12	6	33	9	26	0	0	0	0	0	0	0	59.58	0	0
2025	4	12	6	43	9	26	0	0	0	0	0	0	0	59.52	0	0
2025	4	12	6	53	9	27	0	0	0	0	0	0	0	59.49	0	0
2025	4	12	7	3	9	27	0	0	0	0	0	0	0	59.45	0	0
2025	4	12	7	13	9	26	0	0	0	0	0	0	0	59.45	0	0
2025	4	12	7	23	9	26	0	0	0	0	0	0	0	59.45	0	0
2025	4	12	7	33	9	26	0	0	0	0	0	0	0	59.47	0	0
2025	4	12	7	43	9	26	0	0	0	0	0	0	0	59.5	0	0
2025	4	12	7	53	9	26	0	0	0	0	0	0	0	59.54	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	12	8	3	9	27	0	0	0	0	0	0	0	59.61	0	0
2025	4	12	8	13	9	26	0	0	0	0	0	0	0	59.68	0	0
2025	4	12	8	23	9	27	0	0	0	0	0	0	0	59.76	0	0
2025	4	12	8	33	9	27	0	0	0	0	0	0	0	59.86	0	0
2025	4	12	8	43	9	26	0	0	0	0	0	0	0	59.97	0	0
2025	4	12	8	53	9	27	0	0	0	0	0	0	0	60.1	0	0
2025	4	12	9	3	9	26	0	0	0	0	0	0	0	60.22	0	0
2025	4	12	9	13	9	26	0	0	0	0	0	0	0	60.35	0	0
2025	4	12	9	23	9	27	0	0	0	0	0	0	0	60.49	0	0
2025	4	12	9	33	9	26	0	0	0	0	0	0	0	60.66	0	0
2025	4	12	9	43	9	27	0	0	0	0	0	0	0	60.82	0	0
2025	4	12	9	53	9	26	0	0	0	0	0	0	0	60.98	0	0
2025	4	12	10	3	9	26	0	0	0	0	0	0	0	61.16	0	0
2025	4	12	10	13	9	26	0	0	0	0	0	0	0	61.34	0	0
2025	4	12	10	23	9	26	0	0	0	0	0	0	0	61.52	0	0
2025	4	12	10	33	9	26	0	0	0	0	0	0	0	61.72	0	0
2025	4	12	10	43	9	26	0	0	0	0	0	0	0	61.9	0	0
2025	4	12	10	53	9	26	0	0	0	0	0	0	0	62.11	0	0
2025	4	12	11	3	9	26	0	0	0	0	0	0	0	62.29	0	0
2025	4	12	11	13	9	26	0	0	0	0	0	0	0	62.51	0	0
2025	4	12	11	23	9	26	0	0	0	0	0	0	0	62.73	0	0
2025	4	12	11	33	9	26	0	0	0	0	0	0	0	62.92	0	0
2025	4	12	11	43	9	26	0	0	0	0	0	0	0	63.14	0	0
2025	4	12	11	53	9	26	0	0	0	0	0	0	0	63.36	0	0
2025	4	12	12	3	9	26	0	0	0	0	0	0	0	63.55	0	0
2025	4	12	12	13	9	26	0	0	0	0	0	0	0	63.75	0	0
2025	4	12	12	23	9	26	0	0	0	0	0	0	0	63.97	0	0
2025	4	12	12	33	9	26	0	0	0	0	0	0	0	64.18	0	0
2025	4	12	12	43	9	26	0	0	0	0	0	0	0	64.4	0	0
2025	4	12	12	53	9	26	0	0	0	0	0	0	0	64.6	0	0
2025	4	12	13	3	9	26	0	0	0	0	0	0	0	64.8	0	0
2025	4	12	13	13	9	27	0	0	0	0	0	0	0	64.99	0	0
2025	4	12	13	23	9	26	0	0	0	0	0	0	0	65.17	0	0
2025	4	12	13	33	9	26	0	0	0	0	0	0	0	65.37	0	0
2025	4	12	13	43	9	26	0	0	0	0	0	0	0	65.55	0	0
2025	4	12	13	53	9	26	0	0	0	0	0	0	0	65.73	0	0
2025	4	12	14	3	9	26	0	0	0	0	0	0	0	65.91	0	0
2025	4	12	14	13	9	25	0	0	0	0	0	0	0	66.07	0	0
2025	4	12	14	23	9	25	0	0	0	0	0	0	0	66.22	0	0
2025	4	12	14	33	9	25	0	0	0	0	0	0	0	66.34	0	0
2025	4	12	14	43	9	26	0	0	0	0	0	0	0	66.45	0	0
2025	4	12	14	53	9	26	0	0	0	0	0	0	0	66.56	0	0
2025	4	12	15	3	9	26	0	0	0	0	0	0	0	66.63	0	0
2025	4	12	15	13	9	26	0	0	0	0	0	0	0	66.72	0	0
2025	4	12	15	23	9	25	0	0	0	0	0	0	0	66.79	0	0
2025	4	12	15	33	9	26	0	0	0	0	0	0	0	66.87	0	0
2025	4	12	15	43	9	25	0	0	0	0	0	0	0	66.92	0	0
2025	4	12	15	53	9	26	0	0	0	0	0	0	0	66.96	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	13	0	3	9	26	0	0	0	0	0	0	0	61.99	0	0
2025	4	13	0	13	9	26	0	0	0	0	0	0	0	61.88	0	0
2025	4	13	0	23	9	26	0	0	0	0	0	0	0	61.75	0	0
2025	4	13	0	33	9	26	0	0	0	0	0	0	0	61.63	0	0
2025	4	13	0	43	9	27	0	0	0	0	0	0	0	61.5	0	0
2025	4	13	0	53	9	26	0	0	0	0	0	0	0	61.38	0	0
2025	4	13	1	3	9	26	0	0	0	0	0	0	0	61.25	0	0
2025	4	13	1	13	9	26	0	0	0	0	0	0	0	61.12	0	0
2025	4	13	1	23	9	26	0	0	0	0	0	0	0	61.03	0	0
2025	4	13	1	33	9	26	0	0	0	0	0	0	0	60.93	0	0
2025	4	13	1	43	9	26	0	0	0	0	0	0	0	60.82	0	0
2025	4	13	1	53	9	27	0	0	0	0	0	0	0	60.71	0	0
2025	4	13	2	3	9	26	0	0	0	0	0	0	0	60.6	0	0
2025	4	13	2	13	9	26	0	0	0	0	0	0	0	60.51	0	0
2025	4	13	2	23	9	26	0	0	0	0	0	0	0	60.4	0	0
2025	4	13	2	33	9	26	0	0	0	0	0	0	0	60.31	0	0
2025	4	13	2	43	9	26	0	0	0	0	0	0	0	60.22	0	0
2025	4	13	2	53	9	26	0	0	0	0	0	0	0	60.12	0	0
2025	4	13	3	3	9	26	0	0	0	0	0	0	0	60.01	0	0
2025	4	13	3	13	9	26	0	0	0	0	0	0	0	59.92	0	0
2025	4	13	3	23	9	26	0	0	0	0	0	0	0	59.83	0	0
2025	4	13	3	33	9	26	0	0	0	0	0	0	0	59.74	0	0
2025	4	13	3	43	9	26	0	0	0	0	0	0	0	59.65	0	0
2025	4	13	3	53	9	26	0	0	0	0	0	0	0	59.56	0	0
2025	4	13	4	3	9	26	0	0	0	0	0	0	0	59.45	0	0
2025	4	13	4	13	9	27	0	0	0	0	0	0	0	59.36	0	0
2025	4	13	4	23	9	27	0	0	0	0	0	0	0	59.25	0	0
2025	4	13	4	33	9	27	0	0	0	0	0	0	0	59.14	0	0
2025	4	13	4	43	9	26	0	0	0	0	0	0	0	59.05	0	0
2025	4	13	4	53	9	26	0	0	0	0	0	0	0	58.95	0	0
2025	4	13	5	3	9	27	0	0	0	0	0	0	0	58.84	0	0
2025	4	13	5	13	9	26	0	0	0	0	0	0	0	58.75	0	0
2025	4	13	5	23	9	27	0	0	0	0	0	0	0	58.64	0	0
2025	4	13	5	33	9	27	0	0	0	0	0	0	0	58.55	0	0
2025	4	13	5	43	9	26	0	0	0	0	0	0	0	58.44	0	0
2025	4	13	5	53	9	27	0	0	0	0	0	0	0	58.35	0	0
2025	4	13	6	3	9	26	0	0	0	0	0	0	0	58.26	0	0
2025	4	13	6	13	9	26	0	0	0	0	0	0	0	58.17	0	0
2025	4	13	6	23	9	27	0	0	0	0	0	0	0	58.08	0	0
2025	4	13	6	33	9	27	0	0	0	0	0	0	0	58.01	0	0
2025	4	13	6	43	9	27	0	0	0	0	0	0	0	57.94	0	0
2025	4	13	6	53	9	27	0	0	0	0	0	0	0	57.87	0	0
2025	4	13	7	3	9	27	0	0	0	0	0	0	0	57.83	0	0
2025	4	13	7	13	9	26	0	0	0	0	0	0	0	57.78	0	0
2025	4	13	7	23	9	27	0	0	0	0	0	0	0	57.76	0	0
2025	4	13	7	33	9	27	0	0	0	0	0	0	0	57.74	0	0
2025	4	13	7	43	9	27	0	0	0	0	0	0	0	57.72	0	0
2025	4	13	7	53	9	27	0	0	0	0	0	0	0	57.72	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	13	8	3	9	27	0	0	0	0	0	0	0	57.74	0	0
2025	4	13	8	13	9	27	0	0	0	0	0	0	0	57.76	0	0
2025	4	13	8	23	9	27	0	0	0	0	0	0	0	57.79	0	0
2025	4	13	8	33	9	27	0	0	0	0	0	0	0	57.83	0	0
2025	4	13	8	43	9	27	0	0	0	0	0	0	0	57.88	0	0
2025	4	13	8	53	9	26	0	0	0	0	0	0	0	57.96	0	0
2025	4	13	9	3	9	26	0	0	0	0	0	0	0	58.05	0	0
2025	4	13	9	13	9	27	0	0	0	0	0	0	0	58.12	0	0
2025	4	13	9	23	9	27	0	0	0	0	0	0	0	58.23	0	0
2025	4	13	9	33	9	26	0	0	0	0	0	0	0	58.33	0	0
2025	4	13	9	43	9	27	0	0	0	0	0	0	0	58.46	0	0
2025	4	13	9	53	9	26	0	0	0	0	0	0	0	58.59	0	0
2025	4	13	10	3	9	26	0	0	0	0	0	0	0	58.71	0	0
2025	4	13	10	13	9	26	0	0	0	0	0	0	0	58.87	0	0
2025	4	13	10	23	9	27	0	0	0	0	0	0	0	59.02	0	0
2025	4	13	10	33	9	27	0	0	0	0	0	0	0	59.16	0	0
2025	4	13	10	43	9	27	0	0	0	0	0	0	0	59.32	0	0
2025	4	13	10	53	9	26	0	0	0	0	0	0	0	59.5	0	0
2025	4	13	11	3	9	27	0	0	0	0	0	0	0	59.68	0	0
2025	4	13	11	13	9	27	0	0	0	0	0	0	0	59.86	0	0
2025	4	13	11	23	9	26	0	0	0	0	0	0	0	60.06	0	0
2025	4	13	11	33	9	26	0	0	0	0	0	0	0	60.26	0	0
2025	4	13	11	43	9	26	0	0	0	0	0	0	0	60.48	0	0
2025	4	13	11	53	9	27	0	0	0	0	0	0	0	60.67	0	0
2025	4	13	12	3	9	26	0	0	0	0	0	0	0	60.89	0	0
2025	4	13	12	13	9	26	0	0	0	0	0	0	0	61.11	0	0
2025	4	13	12	23	9	26	0	0	0	0	0	0	0	61.3	0	0
2025	4	13	12	33	9	27	0	0	0	0	0	0	0	61.52	0	0
2025	4	13	12	43	9	26	0	0	0	0	0	0	0	61.72	0	0
2025	4	13	12	53	9	26	0	0	0	0	0	0	0	61.93	0	0
2025	4	13	13	3	9	27	0	0	0	0	0	0	0	62.13	0	0
2025	4	13	13	13	9	26	0	0	0	0	0	0	0	62.35	0	0
2025	4	13	13	23	9	26	0	0	0	0	0	0	0	62.55	0	0
2025	4	13	13	33	9	26	0	0	0	0	0	0	0	62.73	0	0
2025	4	13	13	43	9	27	0	0	0	0	0	0	0	62.91	0	0
2025	4	13	13	53	9	26	0	0	0	0	0	0	0	63.09	0	0
2025	4	13	14	3	9	26	0	0	0	0	0	0	0	63.27	0	0
2025	4	13	14	13	9	26	0	0	0	0	0	0	0	63.45	0	0
2025	4	13	14	23	9	26	0	0	0	0	0	0	0	63.61	0	0
2025	4	13	14	33	9	27	0	0	0	0	0	0	0	63.75	0	0
2025	4	13	14	43	9	25	0	0	0	0	0	0	0	63.9	0	0
2025	4	13	14	53	9	26	0	0	0	0	0	0	0	64.06	0	0
2025	4	13	15	3	9	27	0	0	0	0	0	0	0	64.2	0	0
2025	4	13	15	13	9	26	0	0	0	0	0	0	0	64.33	0	0
2025	4	13	15	23	9	25	0	0	0	0	0	0	0	64.44	0	0
2025	4	13	15	33	9	26	0	0	0	0	0	0	0	64.53	0	0
2025	4	13	15	43	9	25	0	0	0	0	0	0	0	64.58	0	0
2025	4	13	15	53	9	26	0	0	0	0	0	0	0	64.62	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	13	16	3	9	26	0	0	0	0	0	0	0	64.65	0	0
2025	4	13	16	13	9	27	0	0	0	0	0	0	0	64.69	0	0
2025	4	13	16	23	9	26	0	0	0	0	0	0	0	64.71	0	0
2025	4	13	16	33	9	26	0	0	0	0	0	0	0	64.72	0	0
2025	4	13	16	43	9	26	0	0	0	0	0	0	0	64.72	0	0
2025	4	13	16	53	9	26	0	0	0	0	0	0	0	64.71	0	0
2025	4	13	17	3	9	27	0	0	0	0	0	0	0	64.67	0	0
2025	4	13	17	13	9	26	0	0	0	0	0	0	0	64.65	0	0
2025	4	13	17	23	9	26	0	0	0	0	0	0	0	64.62	0	0
2025	4	13	17	33	9	26	0	0	0	0	0	0	0	64.58	0	0
2025	4	13	17	43	9	26	0	0	0	0	0	0	0	64.53	0	0
2025	4	13	17	53	9	26	0	0	0	0	0	0	0	64.47	0	0
2025	4	13	18	3	9	27	0	0	0	0	0	0	0	64.4	0	0
2025	4	13	18	13	9	26	0	0	0	0	0	0	0	64.33	0	0
2025	4	13	18	23	9	26	0	0	0	0	0	0	0	64.26	0	0
2025	4	13	18	33	9	26	0	0	0	0	0	0	0	64.17	0	0
2025	4	13	18	43	9	26	0	0	0	0	0	0	0	64.08	0	0
2025	4	13	18	53	9	26	0	0	0	0	0	0	0	64	0	0
2025	4	13	19	3	9	26	0	0	0	0	0	0	0	63.91	0	0
2025	4	13	19	13	9	26	0	0	0	0	0	0	0	63.82	0	0
2025	4	13	19	23	9	25	0	0	0	0	0	0	0	63.73	0	0
2025	4	13	19	33	9	26	0	0	0	0	0	0	0	63.64	0	0
2025	4	13	19	43	9	26	0	0	0	0	0	0	0	63.55	0	0
2025	4	13	19	53	9	26	0	0	0	0	0	0	0	63.46	0	0
2025	4	13	20	3	9	26	0	0	0	0	0	0	0	63.37	0	0
2025	4	13	20	13	9	26	0	0	0	0	0	0	0	63.28	0	0
2025	4	13	20	23	9	26	0	0	0	0	0	0	0	63.19	0	0
2025	4	13	20	33	9	26	0	0	0	0	0	0	0	63.09	0	0
2025	4	13	20	43	9	26	0	0	0	0	0	0	0	62.98	0	0
2025	4	13	20	53	9	26	0	0	0	0	0	0	0	62.87	0	0
2025	4	13	21	3	9	26	0	0	0	0	0	0	0	62.74	0	0
2025	4	13	21	13	9	26	0	0	0	0	0	0	0	62.64	0	0
2025	4	13	21	23	9	26	0	0	0	0	0	0	0	62.51	0	0
2025	4	13	21	33	9	26	0	0	0	0	0	0	0	62.38	0	0
2025	4	13	21	43	9	26	0	0	0	0	0	0	0	62.26	0	0
2025	4	13	21	53	9	26	0	0	0	0	0	0	0	62.15	0	0
2025	4	13	22	3	9	26	0	0	0	0	0	0	0	62.01	0	0
2025	4	13	22	13	9	26	0	0	0	0	0	0	0	61.88	0	0
2025	4	13	22	23	9	26	0	0	0	0	0	0	0	61.75	0	0
2025	4	13	22	33	9	25	0	0	0	0	0	0	0	61.61	0	0
2025	4	13	22	43	9	27	0	0	0	0	0	0	0	61.48	0	0
2025	4	13	22	53	9	26	0	0	0	0	0	0	0	61.36	0	0
2025	4	13	23	3	9	27	0	0	0	0	0	0	0	61.25	0	0
2025	4	13	23	13	9	26	0	0	0	0	0	0	0	61.12	0	0
2025	4	13	23	23	9	26	0	0	0	0	0	0	0	61	0	0
2025	4	13	23	33	9	26	0	0	0	0	0	0	0	60.89	0	0
2025	4	13	23	43	9	27	0	0	0	0	0	0	0	60.75	0	0
2025	4	13	23	53	9	26	0	0	0	0	0	0	0	60.64	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	14	0	3	9	26	0	0	0	0	0	0	0	60.55	0	0
2025	4	14	0	13	9	26	0	0	0	0	0	0	0	60.46	0	0
2025	4	14	0	23	9	26	0	0	0	0	0	0	0	60.35	0	0
2025	4	14	0	33	9	26	0	0	0	0	0	0	0	60.26	0	0
2025	4	14	0	43	9	27	0	0	0	0	0	0	0	60.17	0	0
2025	4	14	0	53	9	26	0	0	0	0	0	0	0	60.08	0	0
2025	4	14	1	3	9	26	0	0	0	0	0	0	0	59.99	0	0
2025	4	14	1	13	9	26	0	0	0	0	0	0	0	59.9	0	0
2025	4	14	1	23	9	27	0	0	0	0	0	0	0	59.83	0	0
2025	4	14	1	33	9	27	0	0	0	0	0	0	0	59.74	0	0
2025	4	14	1	43	9	26	0	0	0	0	0	0	0	59.65	0	0
2025	4	14	1	53	9	27	0	0	0	0	0	0	0	59.56	0	0
2025	4	14	2	3	9	27	0	0	0	0	0	0	0	59.47	0	0
2025	4	14	2	13	9	26	0	0	0	0	0	0	0	59.4	0	0
2025	4	14	2	23	9	27	0	0	0	0	0	0	0	59.31	0	0
2025	4	14	2	33	9	27	0	0	0	0	0	0	0	59.23	0	0
2025	4	14	2	43	9	27	0	0	0	0	0	0	0	59.16	0	0
2025	4	14	2	53	9	26	0	0	0	0	0	0	0	59.07	0	0
2025	4	14	3	3	9	26	0	0	0	0	0	0	0	59	0	0
2025	4	14	3	13	9	27	0	0	0	0	0	0	0	58.91	0	0
2025	4	14	3	23	9	26	0	0	0	0	0	0	0	58.84	0	0
2025	4	14	3	33	9	26	0	0	0	0	0	0	0	58.77	0	0
2025	4	14	3	43	9	27	0	0	0	0	0	0	0	58.68	0	0
2025	4	14	3	53	9	27	0	0	0	0	0	0	0	58.59	0	0
2025	4	14	4	3	9	26	0	0	0	0	0	0	0	58.5	0	0
2025	4	14	4	13	9	27	0	0	0	0	0	0	0	58.41	0	0
2025	4	14	4	23	9	27	0	0	0	0	0	0	0	58.32	0	0
2025	4	14	4	33	9	27	0	0	0	0	0	0	0	58.23	0	0
2025	4	14	4	43	9	27	0	0	0	0	0	0	0	58.14	0	0
2025	4	14	4	53	9	26	0	0	0	0	0	0	0	58.05	0	0
2025	4	14	5	3	9	27	0	0	0	0	0	0	0	57.97	0	0
2025	4	14	5	13	9	27	0	0	0	0	0	0	0	57.88	0	0
2025	4	14	5	23	9	26	0	0	0	0	0	0	0	57.81	0	0
2025	4	14	5	33	9	27	0	0	0	0	0	0	0	57.74	0	0
2025	4	14	5	43	9	27	0	0	0	0	0	0	0	57.69	0	0
2025	4	14	5	53	9	27	0	0	0	0	0	0	0	57.63	0	0
2025	4	14	6	3	9	27	0	0	0	0	0	0	0	57.6	0	0
2025	4	14	6	13	9	27	0	0	0	0	0	0	0	57.54	0	0
2025	4	14	6	23	9	28	0	0	0	0	0	0	0	57.51	0	0
2025	4	14	6	33	9	27	0	0	0	0	0	0	0	57.49	0	0
2025	4	14	6	43	9	27	0	0	0	0	0	0	0	57.47	0	0
2025	4	14	6	53	9	27	0	0	0	0	0	0	0	57.45	0	0
2025	4	14	7	3	9	26	0	0	0	0	0	0	0	57.45	0	0
2025	4	14	7	13	9	27	0	0	0	0	0	0	0	57.47	0	0
2025	4	14	7	23	9	27	0	0	0	0	0	0	0	57.49	0	0
2025	4	14	7	33	9	26	0	0	0	0	0	0	0	57.54	0	0
2025	4	14	7	43	9	26	0	0	0	0	0	0	0	57.58	0	0
2025	4	14	7	53	9	27	0	0	0	0	0	0	0	57.63	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	14	8	3	9	27	0	0	0	0	0	0	0	57.7	0	0
2025	4	14	8	13	9	27	0	0	0	0	0	0	0	57.79	0	0
2025	4	14	8	23	9	27	0	0	0	0	0	0	0	57.88	0	0
2025	4	14	8	33	9	27	0	0	0	0	0	0	0	57.97	0	0
2025	4	14	8	43	9	27	0	0	0	0	0	0	0	58.1	0	0
2025	4	14	8	53	9	27	0	0	0	0	0	0	0	58.21	0	0
2025	4	14	9	3	9	27	0	0	0	0	0	0	0	58.33	0	0
2025	4	14	9	13	9	27	0	0	0	0	0	0	0	58.44	0	0
2025	4	14	9	23	9	27	0	0	0	0	0	0	0	58.55	0	0
2025	4	14	9	33	9	27	0	0	0	0	0	0	0	58.68	0	0
2025	4	14	9	43	9	26	0	0	0	0	0	0	0	58.84	0	0
2025	4	14	9	53	9	26	0	0	0	0	0	0	0	59	0	0
2025	4	14	10	3	9	27	0	0	0	0	0	0	0	59.16	0	0
2025	4	14	10	13	9	27	0	0	0	0	0	0	0	59.29	0	0
2025	4	14	10	23	9	26	0	0	0	0	0	0	0	59.43	0	0
2025	4	14	10	33	9	27	0	0	0	0	0	0	0	59.58	0	0
2025	4	14	10	43	9	27	0	0	0	0	0	0	0	59.72	0	0
2025	4	14	10	53	9	26	0	0	0	0	0	0	0	59.86	0	0
2025	4	14	11	3	9	26	0	0	0	0	0	0	0	60.03	0	0
2025	4	14	11	13	9	26	0	0	0	0	0	0	0	60.21	0	0
2025	4	14	11	23	9	27	0	0	0	0	0	0	0	60.4	0	0
2025	4	14	11	33	9	26	0	0	0	0	0	0	0	60.6	0	0
2025	4	14	11	43	9	27	0	0	0	0	0	0	0	60.8	0	0
2025	4	14	11	53	9	27	0	0	0	0	0	0	0	60.96	0	0
2025	4	14	12	3	9	26	0	0	0	0	0	0	0	61.11	0	0
2025	4	14	12	13	9	27	0	0	0	0	0	0	0	61.25	0	0
2025	4	14	12	23	9	26	0	0	0	0	0	0	0	61.39	0	0
2025	4	14	12	33	9	26	0	0	0	0	0	0	0	61.59	0	0
2025	4	14	12	43	9	26	0	0	0	0	0	0	0	61.81	0	0
2025	4	14	12	53	9	26	0	0	0	0	0	0	0	62.01	0	0
2025	4	14	13	3	9	27	0	0	0	0	0	0	0	62.17	0	0
2025	4	14	13	13	9	26	0	0	0	0	0	0	0	62.29	0	0
2025	4	14	13	23	9	27	0	0	0	0	0	0	0	62.44	0	0
2025	4	14	13	33	9	26	0	0	0	0	0	0	0	62.58	0	0
2025	4	14	13	43	9	26	0	0	0	0	0	0	0	62.76	0	0
2025	4	14	13	53	9	26	0	0	0	0	0	0	0	62.96	0	0
2025	4	14	14	3	9	26	0	0	0	0	0	0	0	63.14	0	0
2025	4	14	14	13	9	26	0	0	0	0	0	0	0	63.28	0	0
2025	4	14	14	23	9	26	0	0	0	0	0	0	0	63.43	0	0
2025	4	14	14	33	9	27	0	0	0	0	0	0	0	63.55	0	0
2025	4	14	14	43	9	26	0	0	0	0	0	0	0	63.7	0	0
2025	4	14	14	53	9	27	0	0	0	0	0	0	0	63.82	0	0
2025	4	14	15	3	9	26	0	0	0	0	0	0	0	63.93	0	0
2025	4	14	15	13	9	26	0	0	0	0	0	0	0	64.02	0	0
2025	4	14	15	23	9	26	0	0	0	0	0	0	0	64.13	0	0
2025	4	14	15	33	9	26	0	0	0	0	0	0	0	64.22	0	0
2025	4	14	15	43	9	27	0	0	0	0	0	0	0	64.31	0	0
2025	4	14	15	53	9	26	0	0	0	0	0	0	0	64.4	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	14	16	3	9	27	0	0	0	0	0	0	0	64.45	0	0
2025	4	14	16	13	9	26	0	0	0	0	0	0	0	64.49	0	0
2025	4	14	16	23	9	26	0	0	0	0	0	0	0	64.53	0	0
2025	4	14	16	33	9	25	0	0	0	0	0	0	0	64.54	0	0
2025	4	14	16	43	9	26	0	0	0	0	0	0	0	64.56	0	0
2025	4	14	16	53	9	26	0	0	0	0	0	0	0	64.54	0	0
2025	4	14	17	3	9	26	0	0	0	0	0	0	0	64.54	0	0
2025	4	14	17	13	9	26	0	0	0	0	0	0	0	64.51	0	0
2025	4	14	17	23	9	26	0	0	0	0	0	0	0	64.49	0	0
2025	4	14	17	33	9	26	0	0	0	0	0	0	0	64.45	0	0
2025	4	14	17	43	9	26	0	0	0	0	0	0	0	64.4	0	0
2025	4	14	17	53	9	26	0	0	0	0	0	0	0	64.36	0	0
2025	4	14	18	3	9	26	0	0	0	0	0	0	0	64.33	0	0
2025	4	14	18	13	9	26	0	0	0	0	0	0	0	64.27	0	0
2025	4	14	18	23	9	26	0	0	0	0	0	0	0	64.22	0	0
2025	4	14	18	33	9	26	0	0	0	0	0	0	0	64.13	0	0
2025	4	14	18	43	9	26	0	0	0	0	0	0	0	64.08	0	0
2025	4	14	18	53	9	26	0	0	0	0	0	0	0	64	0	0
2025	4	14	19	3	9	25	0	0	0	0	0	0	0	63.91	0	0
2025	4	14	19	13	9	26	0	0	0	0	0	0	0	63.84	0	0
2025	4	14	19	23	9	26	0	0	0	0	0	0	0	63.77	0	0
2025	4	14	19	33	9	26	0	0	0	0	0	0	0	63.68	0	0
2025	4	14	19	43	9	26	0	0	0	0	0	0	0	63.59	0	0
2025	4	14	19	53	9	26	0	0	0	0	0	0	0	63.5	0	0
2025	4	14	20	3	9	27	0	0	0	0	0	0	0	63.39	0	0
2025	4	14	20	13	9	26	0	0	0	0	0	0	0	63.3	0	0
2025	4	14	20	23	9	26	0	0	0	0	0	0	0	63.21	0	0
2025	4	14	20	33	9	26	0	0	0	0	0	0	0	63.12	0	0
2025	4	14	20	43	9	26	0	0	0	0	0	0	0	63.01	0	0
2025	4	14	20	53	9	27	0	0	0	0	0	0	0	62.91	0	0
2025	4	14	21	3	9	26	0	0	0	0	0	0	0	62.82	0	0
2025	4	14	21	13	9	26	0	0	0	0	0	0	0	62.71	0	0
2025	4	14	21	23	9	26	0	0	0	0	0	0	0	62.6	0	0
2025	4	14	21	33	9	27	0	0	0	0	0	0	0	62.49	0	0
2025	4	14	21	43	9	26	0	0	0	0	0	0	0	62.38	0	0
2025	4	14	21	53	9	26	0	0	0	0	0	0	0	62.28	0	0
2025	4	14	22	3	9	27	0	0	0	0	0	0	0	62.15	0	0
2025	4	14	22	13	9	26	0	0	0	0	0	0	0	62.04	0	0
2025	4	14	22	23	9	26	0	0	0	0	0	0	0	61.93	0	0
2025	4	14	22	33	9	26	0	0	0	0	0	0	0	61.81	0	0
2025	4	14	22	43	9	27	0	0	0	0	0	0	0	61.68	0	0
2025	4	14	22	53	9	26	0	0	0	0	0	0	0	61.57	0	0
2025	4	14	23	3	9	27	0	0	0	0	0	0	0	61.45	0	0
2025	4	14	23	13	9	27	0	0	0	0	0	0	0	61.32	0	0
2025	4	14	23	23	9	26	0	0	0	0	0	0	0	61.21	0	0
2025	4	14	23	33	9	26	0	0	0	0	0	0	0	61.09	0	0
2025	4	14	23	43	9	26	0	0	0	0	0	0	0	60.96	0	0
2025	4	14	23	53	9	26	0	0	0	0	0	0	0	60.84	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	15	0	3	9	27	0	0	0	0	0	0	0	60.73	0	0
2025	4	15	0	13	9	26	0	0	0	0	0	0	0	60.6	0	0
2025	4	15	0	23	9	26	0	0	0	0	0	0	0	60.48	0	0
2025	4	15	0	33	9	27	0	0	0	0	0	0	0	60.37	0	0
2025	4	15	0	43	9	26	0	0	0	0	0	0	0	60.26	0	0
2025	4	15	0	53	9	26	0	0	0	0	0	0	0	60.15	0	0
2025	4	15	1	3	9	26	0	0	0	0	0	0	0	60.03	0	0
2025	4	15	1	13	9	27	0	0	0	0	0	0	0	59.92	0	0
2025	4	15	1	23	9	27	0	0	0	0	0	0	0	59.81	0	0
2025	4	15	1	33	9	26	0	0	0	0	0	0	0	59.72	0	0
2025	4	15	1	43	9	26	0	0	0	0	0	0	0	59.61	0	0
2025	4	15	1	53	9	26	0	0	0	0	0	0	0	59.52	0	0
2025	4	15	2	3	9	26	0	0	0	0	0	0	0	59.41	0	0
2025	4	15	2	13	9	26	0	0	0	0	0	0	0	59.34	0	0
2025	4	15	2	23	9	26	0	0	0	0	0	0	0	59.25	0	0
2025	4	15	2	33	9	27	0	0	0	0	0	0	0	59.18	0	0
2025	4	15	2	43	9	27	0	0	0	0	0	0	0	59.11	0	0
2025	4	15	2	53	9	26	0	0	0	0	0	0	0	59.02	0	0
2025	4	15	3	3	9	26	0	0	0	0	0	0	0	58.95	0	0
2025	4	15	3	13	9	27	0	0	0	0	0	0	0	58.87	0	0
2025	4	15	3	23	9	27	0	0	0	0	0	0	0	58.82	0	0
2025	4	15	3	33	9	27	0	0	0	0	0	0	0	58.75	0	0
2025	4	15	3	43	9	27	0	0	0	0	0	0	0	58.68	0	0
2025	4	15	3	53	9	26	0	0	0	0	0	0	0	58.6	0	0
2025	4	15	4	3	9	26	0	0	0	0	0	0	0	58.55	0	0
2025	4	15	4	13	9	26	0	0	0	0	0	0	0	58.48	0	0
2025	4	15	4	23	9	26	0	0	0	0	0	0	0	58.41	0	0
2025	4	15	4	33	9	26	0	0	0	0	0	0	0	58.33	0	0
2025	4	15	4	43	9	26	0	0	0	0	0	0	0	58.26	0	0
2025	4	15	4	53	9	27	0	0	0	0	0	0	0	58.19	0	0
2025	4	15	5	3	9	26	0	0	0	0	0	0	0	58.1	0	0
2025	4	15	5	13	9	27	0	0	0	0	0	0	0	58.01	0	0
2025	4	15	5	23	9	26	0	0	0	0	0	0	0	57.94	0	0
2025	4	15	5	33	9	26	0	0	0	0	0	0	0	57.87	0	0
2025	4	15	5	43	9	27	0	0	0	0	0	0	0	57.79	0	0
2025	4	15	5	53	9	27	0	0	0	0	0	0	0	57.72	0	0
2025	4	15	6	3	9	27	0	0	0	0	0	0	0	57.65	0	0
2025	4	15	6	13	9	26	0	0	0	0	0	0	0	57.6	0	0
2025	4	15	6	23	9	27	0	0	0	0	0	0	0	57.54	0	0
2025	4	15	6	33	9	27	0	0	0	0	0	0	0	57.51	0	0
2025	4	15	6	43	9	26	0	0	0	0	0	0	0	57.47	0	0
2025	4	15	6	53	9	27	0	0	0	0	0	0	0	57.43	0	0
2025	4	15	7	3	9	27	0	0	0	0	0	0	0	57.43	0	0
2025	4	15	7	13	9	27	0	0	0	0	0	0	0	57.43	0	0
2025	4	15	7	23	9	27	0	0	0	0	0	0	0	57.45	0	0
2025	4	15	7	33	9	27	0	0	0	0	0	0	0	57.47	0	0
2025	4	15	7	43	9	27	0	0	0	0	0	0	0	57.51	0	0
2025	4	15	7	53	9	27	0	0	0	0	0	0	0	57.56	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	15	8	3	9	27	0	0	0	0	0	0	0	57.63	0	0
2025	4	15	8	13	9	26	0	0	0	0	0	0	0	57.72	0	0
2025	4	15	8	23	9	27	0	0	0	0	0	0	0	57.81	0	0
2025	4	15	8	33	9	27	0	0	0	0	0	0	0	57.92	0	0
2025	4	15	8	43	9	27	0	0	0	0	0	0	0	58.05	0	0
2025	4	15	8	53	9	26	0	0	0	0	0	0	0	58.17	0	0
2025	4	15	9	3	9	27	0	0	0	0	0	0	0	58.3	0	0
2025	4	15	9	13	9	27	0	0	0	0	0	0	0	58.46	0	0
2025	4	15	9	23	9	27	0	0	0	0	0	0	0	58.62	0	0
2025	4	15	9	33	9	27	0	0	0	0	0	0	0	58.77	0	0
2025	4	15	9	43	9	27	0	0	0	0	0	0	0	58.95	0	0
2025	4	15	9	53	9	27	0	0	0	0	0	0	0	59.13	0	0
2025	4	15	10	3	9	26	0	0	0	0	0	0	0	59.32	0	0
2025	4	15	10	13	9	26	0	0	0	0	0	0	0	59.5	0	0
2025	4	15	10	23	9	27	0	0	0	0	0	0	0	59.7	0	0
2025	4	15	10	33	9	26	0	0	0	0	0	0	0	59.88	0	0
2025	4	15	10	43	9	26	0	0	0	0	0	0	0	60.12	0	0
2025	4	15	10	53	9	26	0	0	0	0	0	0	0	60.35	0	0
2025	4	15	11	3	9	26	0	0	0	0	0	0	0	60.57	0	0
2025	4	15	11	13	9	26	0	0	0	0	0	0	0	60.78	0	0
2025	4	15	11	23	9	27	0	0	0	0	0	0	0	60.98	0	0
2025	4	15	11	33	9	26	0	0	0	0	0	0	0	61.2	0	0
2025	4	15	11	43	9	26	0	0	0	0	0	0	0	61.43	0	0
2025	4	15	11	53	9	26	0	0	0	0	0	0	0	61.66	0	0
2025	4	15	12	3	9	26	0	0	0	0	0	0	0	61.88	0	0
2025	4	15	12	13	9	26	0	0	0	0	0	0	0	62.1	0	0
2025	4	15	12	23	9	26	0	0	0	0	0	0	0	62.31	0	0
2025	4	15	12	33	9	27	0	0	0	0	0	0	0	62.47	0	0
2025	4	15	12	43	9	26	0	0	0	0	0	0	0	62.65	0	0
2025	4	15	12	53	9	26	0	0	0	0	0	0	0	62.82	0	0
2025	4	15	13	3	9	26	0	0	0	0	0	0	0	62.96	0	0
2025	4	15	13	13	9	26	0	0	0	0	0	0	0	63.1	0	0
2025	4	15	13	23	9	26	0	0	0	0	0	0	0	63.21	0	0
2025	4	15	13	33	9	26	0	0	0	0	0	0	0	63.3	0	0
2025	4	15	13	43	9	26	0	0	0	0	0	0	0	63.39	0	0
2025	4	15	13	53	9	25	0	0	0	0	0	0	0	63.45	0	0
2025	4	15	14	3	9	26	0	0	0	0	0	0	0	63.52	0	0
2025	4	15	14	13	9	26	0	0	0	0	0	0	0	63.57	0	0
2025	4	15	14	23	9	26	0	0	0	0	0	0	0	63.61	0	0
2025	4	15	14	33	9	26	0	0	0	0	0	0	0	63.63	0	0
2025	4	15	14	43	9	26	0	0	0	0	0	0	0	63.66	0	0
2025	4	15	14	53	9	26	0	0	0	0	0	0	0	63.72	0	0
2025	4	15	15	3	9	27	0	0	0	0	0	0	0	63.75	0	0
2025	4	15	15	13	9	27	0	0	0	0	0	0	0	63.77	0	0
2025	4	15	15	23	9	26	0	0	0	0	0	0	0	63.82	0	0
2025	4	15	15	33	9	26	0	0	0	0	0	0	0	63.9	0	0
2025	4	15	15	43	9	26	0	0	0	0	0	0	0	63.97	0	0
2025	4	15	15	53	9	26	0	0	0	0	0	0	0	64.02	0	0

Mazourka (0354)

	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	15	16	3	9	26	0	0	0	0	0	0	0	64.06	0	0
2025	4	15	16	13	9	26	0	0	0	0	0	0	0	64.11	0	0
2025	4	15	16	23	9	27	0	0	0	0	0	0	0	64.18	0	0
2025	4	15	16	33	9	26	0	0	0	0	0	0	0	64.22	0	0
2025	4	15	16	43	9	26	0	0	0	0	0	0	0	64.26	0	0
2025	4	15	16	53	9	25	0	0	0	0	0	0	0	64.27	0	0
2025	4	15	17	3	9	26	0	0	0	0	0	0	0	64.27	0	0
2025	4	15	17	13	9	26	0	0	0	0	0	0	0	64.29	0	0
2025	4	15	17	23	9	26	0	0	0	0	0	0	0	64.26	0	0
2025	4	15	17	33	9	26	0	0	0	0	0	0	0	64.26	0	0
2025	4	15	17	43	9	25	0	0	0	0	0	0	0	64.24	0	0
2025	4	15	17	53	9	26	0	0	0	0	0	0	0	64.2	0	0
2025	4	15	18	3	9	26	0	0	0	0	0	0	0	64.15	0	0
2025	4	15	18	13	9	26	0	0	0	0	0	0	0	64.09	0	0
2025	4	15	18	23	9	26	0	0	0	0	0	0	0	64.04	0	0
2025	4	15	18	33	9	26	0	0	0	0	0	0	0	63.97	0	0
2025	4	15	18	43	9	26	0	0	0	0	0	0	0	63.9	0	0
2025	4	15	18	53	9	26	0	0	0	0	0	0	0	63.82	0	0
2025	4	15	19	3	9	26	0	0	0	0	0	0	0	63.75	0	0
2025	4	15	19	13	9	26	0	0	0	0	0	0	0	63.68	0	0
2025	4	15	19	23	9	27	0	0	0	0	0	0	0	63.61	0	0
2025	4	15	19	33	9	26	0	0	0	0	0	0	0	63.54	0	0
2025	4	15	19	43	9	26	0	0	0	0	0	0	0	63.46	0	0
2025	4	15	19	53	9	26	0	0	0	0	0	0	0	63.39	0	0
2025	4	15	20	3	9	27	0	0	0	0	0	0	0	63.32	0	0
2025	4	15	20	13	9	26	0	0	0	0	0	0	0	63.25	0	0
2025	4	15	20	23	9	26	0	0	0	0	0	0	0	63.18	0	0
2025	4	15	20	33	9	27	0	0	0	0	0	0	0	63.1	0	0
2025	4	15	20	43	9	26	0	0	0	0	0	0	0	63.03	0	0
2025	4	15	20	53	9	26	0	0	0	0	0	0	0	62.96	0	0
2025	4	15	21	3	9	26	0	0	0	0	0	0	0	62.87	0	0
2025	4	15	21	13	9	26	0	0	0	0	0	0	0	62.8	0	0
2025	4	15	21	23	9	26	0	0	0	0	0	0	0	62.74	0	0
2025	4	15	21	33	9	26	0	0	0	0	0	0	0	62.65	0	0
2025	4	15	21	43	9	26	0	0	0	0	0	0	0	62.58	0	0
2025	4	15	21	53	9	27	0	0	0	0	0	0	0	62.49	0	0
2025	4	15	22	3	9	27	0	0	0	0	0	0	0	62.4	0	0
2025	4	15	22	13	9	26	0	0	0	0	0	0	0	62.31	0	0
2025	4	15	22	23	9	26	0	0	0	0	0	0	0	62.22	0	0
2025	4	15	22	33	9	26	0	0	0	0	0	0	0	62.13	0	0
2025	4	15	22	43	9	26	0	0	0	0	0	0	0	62.02	0	0
2025	4	15	22	53	9	26	0	0	0	0	0	0	0	61.93	0	0
2025	4	15	23	3	9	26	0	0	0	0	0	0	0	61.84	0	0
2025	4	15	23	13	9	26	0	0	0	0	0	0	0	61.75	0	0
2025	4	15	23	23	9	26	0	0	0	0	0	0	0	61.65	0	0
2025	4	15	23	33	9	27	0	0	0	0	0	0	0	61.56	0	0
2025	4	15	23	43	9	26	0	0	0	0	0	0	0	61.47	0	0
2025	4	15	23	53	9	26	0	0	0	0	0	0	0	61.36	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	16	0	3	9	27	0	0	0	0	0	0	0	61.27	0	0
2025	4	16	0	13	9	27	0	0	0	0	0	0	0	61.18	0	0
2025	4	16	0	23	9	27	0	0	0	0	0	0	0	61.09	0	0
2025	4	16	0	33	9	26	0	0	0	0	0	0	0	60.98	0	0
2025	4	16	0	43	9	26	0	0	0	0	0	0	0	60.91	0	0
2025	4	16	0	53	9	27	0	0	0	0	0	0	0	60.82	0	0
2025	4	16	1	3	9	27	0	0	0	0	0	0	0	60.75	0	0
2025	4	16	1	13	9	27	0	0	0	0	0	0	0	60.66	0	0
2025	4	16	1	23	9	26	0	0	0	0	0	0	0	60.58	0	0
2025	4	16	1	33	9	26	0	0	0	0	0	0	0	60.51	0	0
2025	4	16	1	43	9	26	0	0	0	0	0	0	0	60.44	0	0
2025	4	16	1	53	9	26	0	0	0	0	0	0	0	60.37	0	0
2025	4	16	2	3	9	26	0	0	0	0	0	0	0	60.3	0	0
2025	4	16	2	13	9	26	0	0	0	0	0	0	0	60.22	0	0
2025	4	16	2	23	9	26	0	0	0	0	0	0	0	60.15	0	0
2025	4	16	2	33	9	26	0	0	0	0	0	0	0	60.1	0	0
2025	4	16	2	43	9	26	0	0	0	0	0	0	0	60.03	0	0
2025	4	16	2	53	9	27	0	0	0	0	0	0	0	59.97	0	0
2025	4	16	3	3	9	26	0	0	0	0	0	0	0	59.92	0	0
2025	4	16	3	13	9	26	0	0	0	0	0	0	0	59.86	0	0
2025	4	16	3	23	9	26	0	0	0	0	0	0	0	59.79	0	0
2025	4	16	3	33	9	26	0	0	0	0	0	0	0	59.76	0	0
2025	4	16	3	43	9	27	0	0	0	0	0	0	0	59.68	0	0
2025	4	16	3	53	9	26	0	0	0	0	0	0	0	59.65	0	0
2025	4	16	4	3	9	27	0	0	0	0	0	0	0	59.59	0	0
2025	4	16	4	13	9	27	0	0	0	0	0	0	0	59.54	0	0
2025	4	16	4	23	9	26	0	0	0	0	0	0	0	59.49	0	0
2025	4	16	4	33	9	27	0	0	0	0	0	0	0	59.45	0	0
2025	4	16	4	43	9	27	0	0	0	0	0	0	0	59.4	0	0
2025	4	16	4	53	9	27	0	0	0	0	0	0	0	59.36	0	0
2025	4	16	5	3	9	27	0	0	0	0	0	0	0	59.31	0	0
2025	4	16	5	13	9	27	0	0	0	0	0	0	0	59.27	0	0
2025	4	16	5	23	9	27	0	0	0	0	0	0	0	59.22	0	0
2025	4	16	5	33	9	27	0	0	0	0	0	0	0	59.18	0	0
2025	4	16	5	43	9	27	0	0	0	0	0	0	0	59.14	0	0
2025	4	16	5	53	9	26	0	0	0	0	0	0	0	59.13	0	0
2025	4	16	6	3	9	27	0	0	0	0	0	0	0	59.09	0	0
2025	4	16	6	13	9	27	0	0	0	0	0	0	0	59.07	0	0
2025	4	16	6	23	9	26	0	0	0	0	0	0	0	59.07	0	0
2025	4	16	6	33	9	26	0	0	0	0	0	0	0	59.07	0	0
2025	4	16	6	43	9	26	0	0	0	0	0	0	0	59.07	0	0
2025	4	16	6	53	9	26	0	0	0	0	0	0	0	59.09	0	0
2025	4	16	7	3	9	26	0	0	0	0	0	0	0	59.11	0	0
2025	4	16	7	13	9	26	0	0	0	0	0	0	0	59.13	0	0
2025	4	16	7	23	9	27	0	0	0	0	0	0	0	59.14	0	0
2025	4	16	7	33	9	26	0	0	0	0	0	0	0	59.2	0	0
2025	4	16	7	43	9	27	0	0	0	0	0	0	0	59.25	0	0
2025	4	16	7	53	9	27	0	0	0	0	0	0	0	59.32	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	16	8	3	9	26	0	0	0	0	0	0	0	59.41	0	0
2025	4	16	8	13	9	27	0	0	0	0	0	0	0	59.49	0	0
2025	4	16	8	23	9	27	0	0	0	0	0	0	0	59.58	0	0
2025	4	16	8	33	9	27	0	0	0	0	0	0	0	59.68	0	0
2025	4	16	8	43	9	27	0	0	0	0	0	0	0	59.81	0	0
2025	4	16	8	53	9	26	0	0	0	0	0	0	0	59.92	0	0
2025	4	16	9	3	9	26	0	0	0	0	0	0	0	60.06	0	0
2025	4	16	9	13	9	26	0	0	0	0	0	0	0	60.21	0	0
2025	4	16	9	23	9	26	0	0	0	0	0	0	0	60.35	0	0
2025	4	16	9	33	9	27	0	0	0	0	0	0	0	60.51	0	0
2025	4	16	9	43	9	26	0	0	0	0	0	0	0	60.67	0	0
2025	4	16	9	53	9	26	0	0	0	0	0	0	0	60.84	0	0
2025	4	16	10	3	9	26	0	0	0	0	0	0	0	61.02	0	0
2025	4	16	10	13	9	26	0	0	0	0	0	0	0	61.18	0	0
2025	4	16	10	23	9	27	0	0	0	0	0	0	0	61.36	0	0
2025	4	16	10	33	9	26	0	0	0	0	0	0	0	61.56	0	0
2025	4	16	10	43	9	26	0	0	0	0	0	0	0	61.75	0	0
2025	4	16	10	53	9	26	0	0	0	0	0	0	0	61.93	0	0
2025	4	16	11	3	9	26	0	0	0	0	0	0	0	62.11	0	0
2025	4	16	11	13	9	26	0	0	0	0	0	0	0	62.33	0	0
2025	4	16	11	23	9	26	0	0	0	0	0	0	0	62.53	0	0
2025	4	16	11	33	9	26	0	0	0	0	0	0	0	62.74	0	0
2025	4	16	11	43	9	26	0	0	0	0	0	0	0	62.96	0	0
2025	4	16	11	53	9	27	0	0	0	0	0	0	0	63.16	0	0
2025	4	16	12	3	9	26	0	0	0	0	0	0	0	63.3	0	0
2025	4	16	12	13	9	26	0	0	0	0	0	0	0	63.48	0	0
2025	4	16	12	23	9	26	0	0	0	0	0	0	0	63.68	0	0
2025	4	16	12	33	9	26	0	0	0	0	0	0	0	63.73	0	0
2025	4	16	12	43	9	27	0	0	0	0	0	0	0	63.77	0	0
2025	4	16	12	53	9	26	0	0	0	0	0	0	0	63.82	0	0
2025	4	16	13	3	9	26	0	0	0	0	0	0	0	63.88	0	0
2025	4	16	13	13	9	26	0	0	0	0	0	0	0	63.9	0	0
2025	4	16	13	23	9	26	0	0	0	0	0	0	0	63.9	0	0
2025	4	16	13	33	9	26	0	0	0	0	0	0	0	63.91	0	0
2025	4	16	13	43	9	25	0	0	0	0	0	0	0	63.93	0	0
2025	4	16	13	53	9	26	0	0	0	0	0	0	0	63.93	0	0
2025	4	16	14	3	9	26	0	0	0	0	0	0	0	63.91	0	0
2025	4	16	14	13	9	27	0	0	0	0	0	0	0	63.9	0	0
2025	4	16	14	23	9	26	0	0	0	0	0	0	0	63.91	0	0
2025	4	16	14	33	9	26	0	0	0	0	0	0	0	63.93	0	0
2025	4	16	14	43	9	26	0	0	0	0	0	0	0	63.93	0	0
2025	4	16	14	53	9	27	0	0	0	0	0	0	0	63.93	0	0
2025	4	16	15	3	9	26	0	0	0	0	0	0	0	63.97	0	0
2025	4	16	15	13	9	26	0	0	0	0	0	0	0	64.02	0	0
2025	4	16	15	23	9	26	0	0	0	0	0	0	0	64.08	0	0
2025	4	16	15	33	9	26	0	0	0	0	0	0	0	64.08	0	0
2025	4	16	15	43	9	26	0	0	0	0	0	0	0	64.06	0	0
2025	4	16	15	53	9	26	0	0	0	0	0	0	0	64.06	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	16	16	3	9	26	0	0	0	0	0	0	0	64.02	0	0
2025	4	16	16	13	9	26	0	0	0	0	0	0	0	63.99	0	0
2025	4	16	16	23	9	26	0	0	0	0	0	0	0	63.93	0	0
2025	4	16	16	33	9	26	0	0	0	0	0	0	0	63.9	0	0
2025	4	16	16	43	9	26	0	0	0	0	0	0	0	63.84	0	0
2025	4	16	16	53	9	26	0	0	0	0	0	0	0	63.77	0	0
2025	4	16	17	3	9	26	0	0	0	0	0	0	0	63.7	0	0
2025	4	16	17	13	9	26	0	0	0	0	0	0	0	63.63	0	0
2025	4	16	17	23	9	26	0	0	0	0	0	0	0	63.57	0	0
2025	4	16	17	33	9	26	0	0	0	0	0	0	0	63.52	0	0
2025	4	16	17	43	9	26	0	0	0	0	0	0	0	63.46	0	0
2025	4	16	17	53	9	26	0	0	0	0	0	0	0	63.39	0	0
2025	4	16	18	3	9	26	0	0	0	0	0	0	0	63.34	0	0
2025	4	16	18	13	9	26	0	0	0	0	0	0	0	63.28	0	0
2025	4	16	18	23	9	26	0	0	0	0	0	0	0	63.21	0	0
2025	4	16	18	33	9	27	0	0	0	0	0	0	0	63.16	0	0
2025	4	16	18	43	9	25	0	0	0	0	0	0	0	63.09	0	0
2025	4	16	18	53	9	26	0	0	0	0	0	0	0	63	0	0
2025	4	16	19	3	9	26	0	0	0	0	0	0	0	62.92	0	0
2025	4	16	19	13	9	26	0	0	0	0	0	0	0	62.83	0	0
2025	4	16	19	23	9	25	0	0	0	0	0	0	0	62.74	0	0
2025	4	16	19	33	9	26	0	0	0	0	0	0	0	62.65	0	0
2025	4	16	19	43	9	26	0	0	0	0	0	0	0	62.58	0	0
2025	4	16	19	53	9	26	0	0	0	0	0	0	0	62.47	0	0
2025	4	16	20	3	9	26	0	0	0	0	0	0	0	62.4	0	0
2025	4	16	20	13	9	26	0	0	0	0	0	0	0	62.31	0	0
2025	4	16	20	23	9	26	0	0	0	0	0	0	0	62.24	0	0
2025	4	16	20	33	9	26	0	0	0	0	0	0	0	62.15	0	0
2025	4	16	20	43	9	26	0	0	0	0	0	0	0	62.08	0	0
2025	4	16	20	53	9	26	0	0	0	0	0	0	0	62.01	0	0
2025	4	16	21	3	9	26	0	0	0	0	0	0	0	61.93	0	0
2025	4	16	21	13	9	27	0	0	0	0	0	0	0	61.88	0	0
2025	4	16	21	23	9	26	0	0	0	0	0	0	0	61.81	0	0
2025	4	16	21	33	9	26	0	0	0	0	0	0	0	61.75	0	0
2025	4	16	21	43	9	26	0	0	0	0	0	0	0	61.68	0	0
2025	4	16	21	53	9	26	0	0	0	0	0	0	0	61.63	0	0
2025	4	16	22	3	9	27	0	0	0	0	0	0	0	61.56	0	0
2025	4	16	22	13	9	27	0	0	0	0	0	0	0	61.48	0	0
2025	4	16	22	23	9	26	0	0	0	0	0	0	0	61.43	0	0
2025	4	16	22	33	9	26	0	0	0	0	0	0	0	61.36	0	0
2025	4	16	22	43	9	27	0	0	0	0	0	0	0	61.29	0	0
2025	4	16	22	53	9	26	0	0	0	0	0	0	0	61.23	0	0
2025	4	16	23	3	9	27	0	0	0	0	0	0	0	61.16	0	0
2025	4	16	23	13	9	26	0	0	0	0	0	0	0	61.07	0	0
2025	4	16	23	23	9	26	0	0	0	0	0	0	0	61	0	0
2025	4	16	23	33	9	26	0	0	0	0	0	0	0	60.93	0	0
2025	4	16	23	43	9	27	0	0	0	0	0	0	0	60.85	0	0
2025	4	16	23	53	9	26	0	0	0	0	0	0	0	60.78	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	17	0	3	9	27	0	0	0	0	0	0	0	60.71	0	0
2025	4	17	0	13	9	27	0	0	0	0	0	0	0	60.64	0	0
2025	4	17	0	23	9	26	0	0	0	0	0	0	0	60.58	0	0
2025	4	17	0	33	9	25	0	0	0	0	0	0	0	60.51	0	0
2025	4	17	0	43	9	26	0	0	0	0	0	0	0	60.44	0	0
2025	4	17	0	53	9	26	0	0	0	0	0	0	0	60.39	0	0
2025	4	17	1	3	9	27	0	0	0	0	0	0	0	60.35	0	0
2025	4	17	1	13	9	27	0	0	0	0	0	0	0	60.3	0	0
2025	4	17	1	23	9	27	0	0	0	0	0	0	0	60.24	0	0
2025	4	17	1	33	9	26	0	0	0	0	0	0	0	60.19	0	0
2025	4	17	1	43	9	27	0	0	0	0	0	0	0	60.13	0	0
2025	4	17	1	53	9	26	0	0	0	0	0	0	0	60.08	0	0
2025	4	17	2	3	9	26	0	0	0	0	0	0	0	60.03	0	0
2025	4	17	2	13	9	26	0	0	0	0	0	0	0	59.97	0	0
2025	4	17	2	23	9	27	0	0	0	0	0	0	0	59.92	0	0
2025	4	17	2	33	9	27	0	0	0	0	0	0	0	59.86	0	0
2025	4	17	2	43	9	26	0	0	0	0	0	0	0	59.81	0	0
2025	4	17	2	53	9	27	0	0	0	0	0	0	0	59.77	0	0
2025	4	17	3	3	9	26	0	0	0	0	0	0	0	59.7	0	0
2025	4	17	3	13	9	26	0	0	0	0	0	0	0	59.67	0	0
2025	4	17	3	23	9	26	0	0	0	0	0	0	0	59.61	0	0
2025	4	17	3	33	9	26	0	0	0	0	0	0	0	59.58	0	0
2025	4	17	3	43	9	26	0	0	0	0	0	0	0	59.52	0	0
2025	4	17	3	53	9	28	0	0	0	0	0	0	0	59.49	0	0
2025	4	17	4	3	9	27	0	0	0	0	0	0	0	59.43	0	0
2025	4	17	4	13	9	26	0	0	0	0	0	0	0	59.38	0	0
2025	4	17	4	23	9	26	0	0	0	0	0	0	0	59.32	0	0
2025	4	17	4	33	9	26	0	0	0	0	0	0	0	59.27	0	0
2025	4	17	4	43	9	27	0	0	0	0	0	0	0	59.22	0	0
2025	4	17	4	53	9	26	0	0	0	0	0	0	0	59.16	0	0
2025	4	17	5	3	9	27	0	0	0	0	0	0	0	59.11	0	0
2025	4	17	5	13	9	26	0	0	0	0	0	0	0	59.05	0	0
2025	4	17	5	23	9	26	0	0	0	0	0	0	0	59	0	0
2025	4	17	5	33	9	27	0	0	0	0	0	0	0	58.95	0	0
2025	4	17	5	43	9	27	0	0	0	0	0	0	0	58.89	0	0
2025	4	17	5	53	9	26	0	0	0	0	0	0	0	58.84	0	0
2025	4	17	6	3	9	27	0	0	0	0	0	0	0	58.78	0	0
2025	4	17	6	13	9	27	0	0	0	0	0	0	0	58.73	0	0
2025	4	17	6	23	9	26	0	0	0	0	0	0	0	58.69	0	0
2025	4	17	6	33	9	27	0	0	0	0	0	0	0	58.66	0	0
2025	4	17	6	43	9	26	0	0	0	0	0	0	0	58.64	0	0
2025	4	17	6	53	9	27	0	0	0	0	0	0	0	58.62	0	0
2025	4	17	7	3	9	26	0	0	0	0	0	0	0	58.6	0	0
2025	4	17	7	13	9	26	0	0	0	0	0	0	0	58.6	0	0
2025	4	17	7	23	9	27	0	0	0	0	0	0	0	58.59	0	0
2025	4	17	7	33	9	26	0	0	0	0	0	0	0	58.57	0	0
2025	4	17	7	43	9	27	0	0	0	0	0	0	0	58.57	0	0
2025	4	17	7	53	9	27	0	0	0	0	0	0	0	58.59	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	17	8	3	9	27	0	0	0	0	0	0	0	58.62	0	0
2025	4	17	8	13	9	27	0	0	0	0	0	0	0	58.66	0	0
2025	4	17	8	23	9	26	0	0	0	0	0	0	0	58.66	0	0
2025	4	17	8	33	9	27	0	0	0	0	0	0	0	58.71	0	0
2025	4	17	8	43	9	27	0	0	0	0	0	0	0	58.8	0	0
2025	4	17	8	53	9	26	0	0	0	0	0	0	0	58.91	0	0
2025	4	17	9	3	9	26	0	0	0	0	0	0	0	59.02	0	0
2025	4	17	9	13	9	27	0	0	0	0	0	0	0	59.14	0	0
2025	4	17	9	23	9	26	0	0	0	0	0	0	0	59.27	0	0
2025	4	17	9	33	9	26	0	0	0	0	0	0	0	59.41	0	0
2025	4	17	9	43	9	27	0	0	0	0	0	0	0	59.56	0	0
2025	4	17	9	53	9	27	0	0	0	0	0	0	0	59.72	0	0
2025	4	17	10	3	9	26	0	0	0	0	0	0	0	59.88	0	0
2025	4	17	10	13	9	27	0	0	0	0	0	0	0	60.06	0	0
2025	4	17	10	23	9	26	0	0	0	0	0	0	0	60.26	0	0
2025	4	17	10	33	9	26	0	0	0	0	0	0	0	60.46	0	0
2025	4	17	10	43	9	26	0	0	0	0	0	0	0	60.64	0	0
2025	4	17	10	53	9	26	0	0	0	0	0	0	0	60.84	0	0
2025	4	17	11	3	9	26	0	0	0	0	0	0	0	61.03	0	0
2025	4	17	11	13	9	26	0	0	0	0	0	0	0	61.25	0	0
2025	4	17	11	23	9	27	0	0	0	0	0	0	0	61.47	0	0
2025	4	17	11	33	9	26	0	0	0	0	0	0	0	61.66	0	0
2025	4	17	11	43	9	26	0	0	0	0	0	0	0	61.9	0	0
2025	4	17	11	53	9	26	0	0	0	0	0	0	0	62.1	0	0
2025	4	17	12	3	9	26	0	0	0	0	0	0	0	62.33	0	0
2025	4	17	12	13	9	26	0	0	0	0	0	0	0	62.55	0	0
2025	4	17	12	23	9	27	0	0	0	0	0	0	0	62.76	0	0
2025	4	17	12	33	9	26	0	0	0	0	0	0	0	62.98	0	0
2025	4	17	12	43	9	26	0	0	0	0	0	0	0	63.19	0	0
2025	4	17	12	53	9	26	0	0	0	0	0	0	0	63.37	0	0
2025	4	17	13	3	9	26	0	0	0	0	0	0	0	63.54	0	0
2025	4	17	13	13	9	25	0	0	0	0	0	0	0	63.72	0	0
2025	4	17	13	23	9	26	0	0	0	0	0	0	0	63.84	0	0
2025	4	17	13	33	9	26	0	0	0	0	0	0	0	63.9	0	0
2025	4	17	13	43	9	26	0	0	0	0	0	0	0	63.91	0	0
2025	4	17	13	53	9	26	0	0	0	0	0	0	0	63.93	0	0
2025	4	17	14	3	9	26	0	0	0	0	0	0	0	63.95	0	0
2025	4	17	14	13	9	27	0	0	0	0	0	0	0	63.95	0	0
2025	4	17	14	23	9	26	0	0	0	0	0	0	0	63.99	0	0
2025	4	17	14	33	9	26	0	0	0	0	0	0	0	64.08	0	0
2025	4	17	14	43	9	27	0	0	0	0	0	0	0	64.17	0	0
2025	4	17	14	53	9	26	0	0	0	0	0	0	0	64.22	0	0
2025	4	17	15	3	9	26	0	0	0	0	0	0	0	64.29	0	0
2025	4	17	15	13	9	26	0	0	0	0	0	0	0	64.33	0	0
2025	4	17	15	23	9	26	0	0	0	0	0	0	0	64.38	0	0
2025	4	17	15	33	9	26	0	0	0	0	0	0	0	64.4	0	0
2025	4	17	15	43	9	26	0	0	0	0	0	0	0	64.47	0	0
2025	4	17	15	53	9	26	0	0	0	0	0	0	0	64.51	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	18	0	3	9	27	0	0	0	0	0	0	0	60.49	0	0
2025	4	18	0	13	9	26	0	0	0	0	0	0	0	60.39	0	0
2025	4	18	0	23	9	26	0	0	0	0	0	0	0	60.3	0	0
2025	4	18	0	33	9	26	0	0	0	0	0	0	0	60.19	0	0
2025	4	18	0	43	9	26	0	0	0	0	0	0	0	60.1	0	0
2025	4	18	0	53	9	26	0	0	0	0	0	0	0	60.01	0	0
2025	4	18	1	3	9	27	0	0	0	0	0	0	0	59.94	0	0
2025	4	18	1	13	9	26	0	0	0	0	0	0	0	59.85	0	0
2025	4	18	1	23	9	26	0	0	0	0	0	0	0	59.76	0	0
2025	4	18	1	33	9	27	0	0	0	0	0	0	0	59.63	0	0
2025	4	18	1	43	9	26	0	0	0	0	0	0	0	59.52	0	0
2025	4	18	1	53	9	26	0	0	0	0	0	0	0	59.43	0	0
2025	4	18	2	3	9	27	0	0	0	0	0	0	0	59.32	0	0
2025	4	18	2	13	9	26	0	0	0	0	0	0	0	59.22	0	0
2025	4	18	2	23	9	27	0	0	0	0	0	0	0	59.13	0	0
2025	4	18	2	33	9	27	0	0	0	0	0	0	0	59.02	0	0
2025	4	18	2	43	9	26	0	0	0	0	0	0	0	58.91	0	0
2025	4	18	2	53	9	26	0	0	0	0	0	0	0	58.8	0	0
2025	4	18	3	3	9	27	0	0	0	0	0	0	0	58.71	0	0
2025	4	18	3	13	9	27	0	0	0	0	0	0	0	58.6	0	0
2025	4	18	3	23	9	27	0	0	0	0	0	0	0	58.51	0	0
2025	4	18	3	33	9	26	0	0	0	0	0	0	0	58.44	0	0
2025	4	18	3	43	9	27	0	0	0	0	0	0	0	58.37	0	0
2025	4	18	3	53	9	26	0	0	0	0	0	0	0	58.3	0	0
2025	4	18	4	3	9	26	0	0	0	0	0	0	0	58.23	0	0
2025	4	18	4	13	9	26	0	0	0	0	0	0	0	58.15	0	0
2025	4	18	4	23	9	26	0	0	0	0	0	0	0	58.08	0	0
2025	4	18	4	33	9	26	0	0	0	0	0	0	0	58.03	0	0
2025	4	18	4	43	9	27	0	0	0	0	0	0	0	57.96	0	0
2025	4	18	4	53	9	27	0	0	0	0	0	0	0	57.88	0	0
2025	4	18	5	3	9	26	0	0	0	0	0	0	0	57.83	0	0
2025	4	18	5	13	9	27	0	0	0	0	0	0	0	57.76	0	0
2025	4	18	5	23	9	26	0	0	0	0	0	0	0	57.69	0	0
2025	4	18	5	33	9	27	0	0	0	0	0	0	0	57.61	0	0
2025	4	18	5	43	9	26	0	0	0	0	0	0	0	57.54	0	0
2025	4	18	5	53	9	27	0	0	0	0	0	0	0	57.47	0	0
2025	4	18	6	3	9	27	0	0	0	0	0	0	0	57.38	0	0
2025	4	18	6	13	9	27	0	0	0	0	0	0	0	57.29	0	0
2025	4	18	6	23	9	27	0	0	0	0	0	0	0	57.22	0	0
2025	4	18	6	33	9	27	0	0	0	0	0	0	0	57.13	0	0
2025	4	18	6	43	9	26	0	0	0	0	0	0	0	57.04	0	0
2025	4	18	6	53	9	27	0	0	0	0	0	0	0	56.95	0	0
2025	4	18	7	3	9	27	0	0	0	0	0	0	0	56.88	0	0
2025	4	18	7	13	9	27	0	0	0	0	0	0	0	56.79	0	0
2025	4	18	7	23	9	26	0	0	0	0	0	0	0	56.71	0	0
2025	4	18	7	33	9	27	0	0	0	0	0	0	0	56.66	0	0
2025	4	18	7	43	9	28	0	0	0	0	0	0	0	56.62	0	0
2025	4	18	7	53	9	26	0	0	0	0	0	0	0	56.61	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	18	8	3	9	27	0	0	0	0	0	0	0	56.59	0	0
2025	4	18	8	13	9	27	0	0	0	0	0	0	0	56.59	0	0
2025	4	18	8	23	9	27	0	0	0	0	0	0	0	56.59	0	0
2025	4	18	8	33	9	26	0	0	0	0	0	0	0	56.61	0	0
2025	4	18	8	43	9	27	0	0	0	0	0	0	0	56.64	0	0
2025	4	18	8	53	9	27	0	0	0	0	0	0	0	56.68	0	0
2025	4	18	9	3	9	26	0	0	0	0	0	0	0	56.71	0	0
2025	4	18	9	13	9	26	0	0	0	0	0	0	0	56.77	0	0
2025	4	18	9	23	9	28	0	0	0	0	0	0	0	56.86	0	0
2025	4	18	9	33	9	26	0	0	0	0	0	0	0	56.95	0	0
2025	4	18	9	43	9	26	0	0	0	0	0	0	0	57.06	0	0
2025	4	18	9	53	9	26	0	0	0	0	0	0	0	57.16	0	0
2025	4	18	10	3	9	27	0	0	0	0	0	0	0	57.25	0	0
2025	4	18	10	13	9	27	0	0	0	0	0	0	0	57.4	0	0
2025	4	18	10	23	9	26	0	0	0	0	0	0	0	57.54	0	0
2025	4	18	10	33	9	27	0	0	0	0	0	0	0	57.69	0	0
2025	4	18	10	43	9	27	0	0	0	0	0	0	0	57.83	0	0
2025	4	18	10	53	9	27	0	0	0	0	0	0	0	58.01	0	0
2025	4	18	11	3	9	26	0	0	0	0	0	0	0	58.17	0	0
2025	4	18	11	13	9	26	0	0	0	0	0	0	0	58.33	0	0
2025	4	18	11	23	9	27	0	0	0	0	0	0	0	58.51	0	0
2025	4	18	11	33	9	26	0	0	0	0	0	0	0	58.69	0	0
2025	4	18	11	43	9	26	0	0	0	0	0	0	0	58.86	0	0
2025	4	18	11	53	9	27	0	0	0	0	0	0	0	59.02	0	0
2025	4	18	12	3	9	26	0	0	0	0	0	0	0	59.2	0	0
2025	4	18	12	13	9	27	0	0	0	0	0	0	0	59.38	0	0
2025	4	18	12	23	9	26	0	0	0	0	0	0	0	59.56	0	0
2025	4	18	12	33	9	27	0	0	0	0	0	0	0	59.72	0	0
2025	4	18	12	43	9	27	0	0	0	0	0	0	0	59.9	0	0
2025	4	18	12	53	9	27	0	0	0	0	0	0	0	60.04	0	0
2025	4	18	13	3	9	26	0	0	0	0	0	0	0	60.19	0	0
2025	4	18	13	13	9	27	0	0	0	0	0	0	0	60.35	0	0
2025	4	18	13	23	9	26	0	0	0	0	0	0	0	60.48	0	0
2025	4	18	13	33	9	27	0	0	0	0	0	0	0	60.62	0	0
2025	4	18	13	43	9	26	0	0	0	0	0	0	0	60.73	0	0
2025	4	18	13	53	9	26	0	0	0	0	0	0	0	60.85	0	0
2025	4	18	14	3	9	26	0	0	0	0	0	0	0	60.96	0	0
2025	4	18	14	13	9	27	0	0	0	0	0	0	0	61.07	0	0
2025	4	18	14	23	9	26	0	0	0	0	0	0	0	61.16	0	0
2025	4	18	14	33	9	26	0	0	0	0	0	0	0	61.25	0	0
2025	4	18	14	43	9	27	0	0	0	0	0	0	0	61.3	0	0
2025	4	18	14	53	9	26	0	0	0	0	0	0	0	61.38	0	0
2025	4	18	15	3	9	27	0	0	0	0	0	0	0	61.43	0	0
2025	4	18	15	13	9	27	0	0	0	0	0	0	0	61.48	0	0
2025	4	18	15	23	9	26	0	0	0	0	0	0	0	61.54	0	0
2025	4	18	15	33	9	26	0	0	0	0	0	0	0	61.56	0	0
2025	4	18	15	43	9	27	0	0	0	0	0	0	0	61.57	0	0
2025	4	18	15	53	9	26	0	0	0	0	0	0	0	61.59	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	19	0	3	9	26	0	0	0	0	0	0	0	55.89	0	0
2025	4	19	0	13	9	27	0	0	0	0	0	0	0	55.8	0	0
2025	4	19	0	23	9	26	0	0	0	0	0	0	0	55.69	0	0
2025	4	19	0	33	9	27	0	0	0	0	0	0	0	55.56	0	0
2025	4	19	0	43	9	27	0	0	0	0	0	0	0	55.45	0	0
2025	4	19	0	53	9	27	0	0	0	0	0	0	0	55.36	0	0
2025	4	19	1	3	9	26	0	0	0	0	0	0	0	55.26	0	0
2025	4	19	1	13	9	27	0	0	0	0	0	0	0	55.13	0	0
2025	4	19	1	23	9	27	0	0	0	0	0	0	0	55.04	0	0
2025	4	19	1	33	9	27	0	0	0	0	0	0	0	54.93	0	0
2025	4	19	1	43	9	27	0	0	0	0	0	0	0	54.84	0	0
2025	4	19	1	53	9	27	0	0	0	0	0	0	0	54.75	0	0
2025	4	19	2	3	9	27	0	0	0	0	0	0	0	54.64	0	0
2025	4	19	2	13	9	26	0	0	0	0	0	0	0	54.55	0	0
2025	4	19	2	23	9	27	0	0	0	0	0	0	0	54.45	0	0
2025	4	19	2	33	9	27	0	0	0	0	0	0	0	54.36	0	0
2025	4	19	2	43	9	27	0	0	0	0	0	0	0	54.28	0	0
2025	4	19	2	53	9	26	0	0	0	0	0	0	0	54.21	0	0
2025	4	19	3	3	9	27	0	0	0	0	0	0	0	54.12	0	0
2025	4	19	3	13	9	27	0	0	0	0	0	0	0	54.05	0	0
2025	4	19	3	23	9	27	0	0	0	0	0	0	0	53.98	0	0
2025	4	19	3	33	9	27	0	0	0	0	0	0	0	53.89	0	0
2025	4	19	3	43	9	27	0	0	0	0	0	0	0	53.83	0	0
2025	4	19	3	53	9	27	0	0	0	0	0	0	0	53.74	0	0
2025	4	19	4	3	9	27	0	0	0	0	0	0	0	53.67	0	0
2025	4	19	4	13	9	27	0	0	0	0	0	0	0	53.6	0	0
2025	4	19	4	23	9	27	0	0	0	0	0	0	0	53.51	0	0
2025	4	19	4	33	9	27	0	0	0	0	0	0	0	53.42	0	0
2025	4	19	4	43	9	27	0	0	0	0	0	0	0	53.33	0	0
2025	4	19	4	53	9	27	0	0	0	0	0	0	0	53.26	0	0
2025	4	19	5	3	9	27	0	0	0	0	0	0	0	53.17	0	0
2025	4	19	5	13	9	27	0	0	0	0	0	0	0	53.1	0	0
2025	4	19	5	23	9	27	0	0	0	0	0	0	0	53.01	0	0
2025	4	19	5	33	9	27	0	0	0	0	0	0	0	52.93	0	0
2025	4	19	5	43	9	27	0	0	0	0	0	0	0	52.84	0	0
2025	4	19	5	53	9	27	0	0	0	0	0	0	0	52.77	0	0
2025	4	19	6	3	9	27	0	0	0	0	0	0	0	52.7	0	0
2025	4	19	6	13	9	27	0	0	0	0	0	0	0	52.66	0	0
2025	4	19	6	23	9	27	0	0	0	0	0	0	0	52.61	0	0
2025	4	19	6	33	9	27	0	0	0	0	0	0	0	52.59	0	0
2025	4	19	6	43	9	27	0	0	0	0	0	0	0	52.56	0	0
2025	4	19	6	53	9	28	0	0	0	0	0	0	0	52.56	0	0
2025	4	19	7	3	9	27	0	0	0	0	0	0	0	52.54	0	0
2025	4	19	7	13	9	27	0	0	0	0	0	0	0	52.54	0	0
2025	4	19	7	23	9	28	0	0	0	0	0	0	0	52.56	0	0
2025	4	19	7	33	9	27	0	0	0	0	0	0	0	52.57	0	0
2025	4	19	7	43	9	27	0	0	0	0	0	0	0	52.63	0	0
2025	4	19	7	53	9	27	0	0	0	0	0	0	0	52.68	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	19	8	3	9	27	0	0	0	0	0	0	0	52.74	0	0
2025	4	19	8	13	9	27	0	0	0	0	0	0	0	52.83	0	0
2025	4	19	8	23	9	27	0	0	0	0	0	0	0	52.92	0	0
2025	4	19	8	33	9	27	0	0	0	0	0	0	0	53.02	0	0
2025	4	19	8	43	9	27	0	0	0	0	0	0	0	53.11	0	0
2025	4	19	8	53	9	27	0	0	0	0	0	0	0	53.24	0	0
2025	4	19	9	3	9	28	0	0	0	0	0	0	0	53.35	0	0
2025	4	19	9	13	9	27	0	0	0	0	0	0	0	53.49	0	0
2025	4	19	9	23	9	27	0	0	0	0	0	0	0	53.64	0	0
2025	4	19	9	33	9	27	0	0	0	0	0	0	0	53.78	0	0
2025	4	19	9	43	9	26	0	0	0	0	0	0	0	53.94	0	0
2025	4	19	9	53	9	26	0	0	0	0	0	0	0	54.12	0	0
2025	4	19	10	3	9	27	0	0	0	0	0	0	0	54.28	0	0
2025	4	19	10	13	9	28	0	0	0	0	0	0	0	54.46	0	0
2025	4	19	10	23	9	27	0	0	0	0	0	0	0	54.64	0	0
2025	4	19	10	33	9	27	0	0	0	0	0	0	0	54.84	0	0
2025	4	19	10	43	9	27	0	0	0	0	0	0	0	55.06	0	0
2025	4	19	10	53	9	26	0	0	0	0	0	0	0	55.27	0	0
2025	4	19	11	3	9	27	0	0	0	0	0	0	0	55.49	0	0
2025	4	19	11	13	9	27	0	0	0	0	0	0	0	55.69	0	0
2025	4	19	11	23	9	27	0	0	0	0	0	0	0	55.9	0	0
2025	4	19	11	33	9	27	0	0	0	0	0	0	0	56.14	0	0
2025	4	19	11	43	9	27	0	0	0	0	0	0	0	56.35	0	0
2025	4	19	11	53	9	27	0	0	0	0	0	0	0	56.59	0	0
2025	4	19	12	3	9	27	0	0	0	0	0	0	0	56.82	0	0
2025	4	19	12	13	9	27	0	0	0	0	0	0	0	57.04	0	0
2025	4	19	12	23	9	27	0	0	0	0	0	0	0	57.27	0	0
2025	4	19	12	33	9	26	0	0	0	0	0	0	0	57.51	0	0
2025	4	19	12	43	9	27	0	0	0	0	0	0	0	57.72	0	0
2025	4	19	12	53	9	27	0	0	0	0	0	0	0	57.94	0	0
2025	4	19	13	3	9	27	0	0	0	0	0	0	0	58.15	0	0
2025	4	19	13	13	9	27	0	0	0	0	0	0	0	58.35	0	0
2025	4	19	13	23	9	26	0	0	0	0	0	0	0	58.57	0	0
2025	4	19	13	33	9	27	0	0	0	0	0	0	0	58.77	0	0
2025	4	19	13	43	9	27	0	0	0	0	0	0	0	58.96	0	0
2025	4	19	13	53	9	26	0	0	0	0	0	0	0	59.14	0	0
2025	4	19	14	3	9	26	0	0	0	0	0	0	0	59.34	0	0
2025	4	19	14	13	9	27	0	0	0	0	0	0	0	59.5	0	0
2025	4	19	14	23	9	27	0	0	0	0	0	0	0	59.67	0	0
2025	4	19	14	33	9	27	0	0	0	0	0	0	0	59.81	0	0
2025	4	19	14	43	9	27	0	0	0	0	0	0	0	59.97	0	0
2025	4	19	14	53	9	27	0	0	0	0	0	0	0	60.12	0	0
2025	4	19	15	3	9	27	0	0	0	0	0	0	0	60.24	0	0
2025	4	19	15	13	9	26	0	0	0	0	0	0	0	60.37	0	0
2025	4	19	15	23	9	26	0	0	0	0	0	0	0	60.48	0	0
2025	4	19	15	33	9	26	0	0	0	0	0	0	0	60.57	0	0
2025	4	19	15	43	9	26	0	0	0	0	0	0	0	60.66	0	0
2025	4	19	15	53	9	26	0	0	0	0	0	0	0	60.73	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	20	0	3	9	27	0	0	0	0	0	0	0	57.67	0	0
2025	4	20	0	13	9	27	0	0	0	0	0	0	0	57.58	0	0
2025	4	20	0	23	9	27	0	0	0	0	0	0	0	57.49	0	0
2025	4	20	0	33	9	26	0	0	0	0	0	0	0	57.38	0	0
2025	4	20	0	43	9	26	0	0	0	0	0	0	0	57.29	0	0
2025	4	20	0	53	9	27	0	0	0	0	0	0	0	57.2	0	0
2025	4	20	1	3	9	27	0	0	0	0	0	0	0	57.11	0	0
2025	4	20	1	13	9	27	0	0	0	0	0	0	0	57.02	0	0
2025	4	20	1	23	9	26	0	0	0	0	0	0	0	56.93	0	0
2025	4	20	1	33	9	27	0	0	0	0	0	0	0	56.82	0	0
2025	4	20	1	43	9	26	0	0	0	0	0	0	0	56.75	0	0
2025	4	20	1	53	9	27	0	0	0	0	0	0	0	56.66	0	0
2025	4	20	2	3	9	26	0	0	0	0	0	0	0	56.57	0	0
2025	4	20	2	13	9	27	0	0	0	0	0	0	0	56.48	0	0
2025	4	20	2	23	9	27	0	0	0	0	0	0	0	56.41	0	0
2025	4	20	2	33	9	27	0	0	0	0	0	0	0	56.34	0	0
2025	4	20	2	43	9	27	0	0	0	0	0	0	0	56.25	0	0
2025	4	20	2	53	9	27	0	0	0	0	0	0	0	56.16	0	0
2025	4	20	3	3	9	27	0	0	0	0	0	0	0	56.08	0	0
2025	4	20	3	13	9	27	0	0	0	0	0	0	0	56.01	0	0
2025	4	20	3	23	9	26	0	0	0	0	0	0	0	55.92	0	0
2025	4	20	3	33	9	26	0	0	0	0	0	0	0	55.85	0	0
2025	4	20	3	43	9	26	0	0	0	0	0	0	0	55.76	0	0
2025	4	20	3	53	9	27	0	0	0	0	0	0	0	55.69	0	0
2025	4	20	4	3	9	27	0	0	0	0	0	0	0	55.62	0	0
2025	4	20	4	13	9	27	0	0	0	0	0	0	0	55.53	0	0
2025	4	20	4	23	9	27	0	0	0	0	0	0	0	55.45	0	0
2025	4	20	4	33	9	27	0	0	0	0	0	0	0	55.38	0	0
2025	4	20	4	43	9	27	0	0	0	0	0	0	0	55.31	0	0
2025	4	20	4	53	9	26	0	0	0	0	0	0	0	55.24	0	0
2025	4	20	5	3	9	26	0	0	0	0	0	0	0	55.17	0	0
2025	4	20	5	13	9	27	0	0	0	0	0	0	0	55.08	0	0
2025	4	20	5	23	9	27	0	0	0	0	0	0	0	55	0	0
2025	4	20	5	33	9	26	0	0	0	0	0	0	0	54.93	0	0
2025	4	20	5	43	9	28	0	0	0	0	0	0	0	54.86	0	0
2025	4	20	5	53	9	27	0	0	0	0	0	0	0	54.79	0	0
2025	4	20	6	3	9	27	0	0	0	0	0	0	0	54.72	0	0
2025	4	20	6	13	9	27	0	0	0	0	0	0	0	54.66	0	0
2025	4	20	6	23	9	27	0	0	0	0	0	0	0	54.61	0	0
2025	4	20	6	33	9	27	0	0	0	0	0	0	0	54.57	0	0
2025	4	20	6	43	9	27	0	0	0	0	0	0	0	54.54	0	0
2025	4	20	6	53	9	27	0	0	0	0	0	0	0	54.5	0	0
2025	4	20	7	3	9	27	0	0	0	0	0	0	0	54.5	0	0
2025	4	20	7	13	9	27	0	0	0	0	0	0	0	54.5	0	0
2025	4	20	7	23	9	27	0	0	0	0	0	0	0	54.52	0	0
2025	4	20	7	33	9	27	0	0	0	0	0	0	0	54.55	0	0
2025	4	20	7	43	9	27	0	0	0	0	0	0	0	54.59	0	0
2025	4	20	7	53	9	27	0	0	0	0	0	0	0	54.66	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	20	8	3	9	27	0	0	0	0	0	0	0	54.73	0	0
2025	4	20	8	13	9	27	0	0	0	0	0	0	0	54.82	0	0
2025	4	20	8	23	9	27	0	0	0	0	0	0	0	54.91	0	0
2025	4	20	8	33	9	27	0	0	0	0	0	0	0	55.02	0	0
2025	4	20	8	43	9	27	0	0	0	0	0	0	0	55.15	0	0
2025	4	20	8	53	9	27	0	0	0	0	0	0	0	55.27	0	0
2025	4	20	9	3	9	27	0	0	0	0	0	0	0	55.42	0	0
2025	4	20	9	13	9	27	0	0	0	0	0	0	0	55.58	0	0
2025	4	20	9	23	9	27	0	0	0	0	0	0	0	55.74	0	0
2025	4	20	9	33	9	27	0	0	0	0	0	0	0	55.9	0	0
2025	4	20	9	43	9	26	0	0	0	0	0	0	0	56.08	0	0
2025	4	20	9	53	9	27	0	0	0	0	0	0	0	56.26	0	0
2025	4	20	10	3	9	27	0	0	0	0	0	0	0	56.44	0	0
2025	4	20	10	13	9	27	0	0	0	0	0	0	0	56.64	0	0
2025	4	20	10	23	9	26	0	0	0	0	0	0	0	56.86	0	0
2025	4	20	10	33	9	27	0	0	0	0	0	0	0	57.06	0	0
2025	4	20	10	43	9	27	0	0	0	0	0	0	0	57.27	0	0
2025	4	20	10	53	9	27	0	0	0	0	0	0	0	57.47	0	0
2025	4	20	11	3	9	27	0	0	0	0	0	0	0	57.7	0	0
2025	4	20	11	13	9	27	0	0	0	0	0	0	0	57.94	0	0
2025	4	20	11	23	9	27	0	0	0	0	0	0	0	58.15	0	0
2025	4	20	11	33	9	27	0	0	0	0	0	0	0	58.37	0	0
2025	4	20	11	43	9	26	0	0	0	0	0	0	0	58.6	0	0
2025	4	20	11	53	9	26	0	0	0	0	0	0	0	58.84	0	0
2025	4	20	12	3	9	27	0	0	0	0	0	0	0	59.05	0	0
2025	4	20	12	13	9	26	0	0	0	0	0	0	0	59.31	0	0
2025	4	20	12	23	9	26	0	0	0	0	0	0	0	59.54	0	0
2025	4	20	12	33	9	27	0	0	0	0	0	0	0	59.76	0	0
2025	4	20	12	43	9	26	0	0	0	0	0	0	0	59.97	0	0
2025	4	20	12	53	9	26	0	0	0	0	0	0	0	60.19	0	0
2025	4	20	13	3	9	27	0	0	0	0	0	0	0	60.39	0	0
2025	4	20	13	13	9	26	0	0	0	0	0	0	0	60.6	0	0
2025	4	20	13	23	9	26	0	0	0	0	0	0	0	60.8	0	0
2025	4	20	13	33	9	27	0	0	0	0	0	0	0	61	0	0
2025	4	20	13	43	9	26	0	0	0	0	0	0	0	61.2	0	0
2025	4	20	13	53	9	26	0	0	0	0	0	0	0	61.38	0	0
2025	4	20	14	3	9	26	0	0	0	0	0	0	0	61.54	0	0
2025	4	20	14	13	9	27	0	0	0	0	0	0	0	61.72	0	0
2025	4	20	14	23	9	26	0	0	0	0	0	0	0	61.86	0	0
2025	4	20	14	33	9	27	0	0	0	0	0	0	0	62.02	0	0
2025	4	20	14	43	9	26	0	0	0	0	0	0	0	62.17	0	0
2025	4	20	14	53	9	26	0	0	0	0	0	0	0	62.31	0	0
2025	4	20	15	3	9	26	0	0	0	0	0	0	0	62.44	0	0
2025	4	20	15	13	9	26	0	0	0	0	0	0	0	62.55	0	0
2025	4	20	15	23	9	26	0	0	0	0	0	0	0	62.65	0	0
2025	4	20	15	33	9	26	0	0	0	0	0	0	0	62.74	0	0
2025	4	20	15	43	9	26	0	0	0	0	0	0	0	62.83	0	0
2025	4	20	15	53	9	26	0	0	0	0	0	0	0	62.91	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	20	16	3	9	26	0	0	0	0	0	0	0	62.98	0	0
2025	4	20	16	13	9	26	0	0	0	0	0	0	0	63.01	0	0
2025	4	20	16	23	9	26	0	0	0	0	0	0	0	63.05	0	0
2025	4	20	16	33	9	27	0	0	0	0	0	0	0	63.07	0	0
2025	4	20	16	43	9	26	0	0	0	0	0	0	0	63.09	0	0
2025	4	20	16	53	9	26	0	0	0	0	0	0	0	63.09	0	0
2025	4	20	17	3	9	26	0	0	0	0	0	0	0	63.09	0	0
2025	4	20	17	13	9	26	0	0	0	0	0	0	0	63.07	0	0
2025	4	20	17	23	9	26	0	0	0	0	0	0	0	63.05	0	0
2025	4	20	17	33	9	26	0	0	0	0	0	0	0	63	0	0
2025	4	20	17	43	9	27	0	0	0	0	0	0	0	62.96	0	0
2025	4	20	17	53	9	26	0	0	0	0	0	0	0	62.91	0	0
2025	4	20	18	3	9	27	0	0	0	0	0	0	0	62.85	0	0
2025	4	20	18	13	9	26	0	0	0	0	0	0	0	62.82	0	0
2025	4	20	18	23	9	26	0	0	0	0	0	0	0	62.74	0	0
2025	4	20	18	33	9	25	0	0	0	0	0	0	0	62.69	0	0
2025	4	20	18	43	9	27	0	0	0	0	0	0	0	62.62	0	0
2025	4	20	18	53	9	26	0	0	0	0	0	0	0	62.55	0	0
2025	4	20	19	3	9	27	0	0	0	0	0	0	0	62.47	0	0
2025	4	20	19	13	9	26	0	0	0	0	0	0	0	62.4	0	0
2025	4	20	19	23	9	26	0	0	0	0	0	0	0	62.33	0	0
2025	4	20	19	33	9	26	0	0	0	0	0	0	0	62.24	0	0
2025	4	20	19	43	9	27	0	0	0	0	0	0	0	62.17	0	0
2025	4	20	19	53	9	26	0	0	0	0	0	0	0	62.08	0	0
2025	4	20	20	3	9	26	0	0	0	0	0	0	0	62.01	0	0
2025	4	20	20	13	9	26	0	0	0	0	0	0	0	61.92	0	0
2025	4	20	20	23	9	27	0	0	0	0	0	0	0	61.84	0	0
2025	4	20	20	33	9	27	0	0	0	0	0	0	0	61.75	0	0
2025	4	20	20	43	9	27	0	0	0	0	0	0	0	61.7	0	0
2025	4	20	20	53	9	27	0	0	0	0	0	0	0	61.61	0	0
2025	4	20	21	3	9	26	0	0	0	0	0	0	0	61.52	0	0
2025	4	20	21	13	9	26	0	0	0	0	0	0	0	61.43	0	0
2025	4	20	21	23	9	26	0	0	0	0	0	0	0	61.34	0	0
2025	4	20	21	33	9	27	0	0	0	0	0	0	0	61.25	0	0
2025	4	20	21	43	9	26	0	0	0	0	0	0	0	61.16	0	0
2025	4	20	21	53	9	27	0	0	0	0	0	0	0	61.07	0	0
2025	4	20	22	3	9	26	0	0	0	0	0	0	0	60.96	0	0
2025	4	20	22	13	9	27	0	0	0	0	0	0	0	60.87	0	0
2025	4	20	22	23	9	27	0	0	0	0	0	0	0	60.76	0	0
2025	4	20	22	33	9	26	0	0	0	0	0	0	0	60.67	0	0
2025	4	20	22	43	9	26	0	0	0	0	0	0	0	60.57	0	0
2025	4	20	22	53	9	26	0	0	0	0	0	0	0	60.46	0	0
2025	4	20	23	3	9	26	0	0	0	0	0	0	0	60.37	0	0
2025	4	20	23	13	9	26	0	0	0	0	0	0	0	60.28	0	0
2025	4	20	23	23	9	26	0	0	0	0	0	0	0	60.17	0	0
2025	4	20	23	33	9	26	0	0	0	0	0	0	0	60.06	0	0
2025	4	20	23	43	9	27	0	0	0	0	0	0	0	59.97	0	0
2025	4	20	23	53	9	26	0	0	0	0	0	0	0	59.86	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	4	21	0	3	9	27	0	0	0	0	0	0	0	59.77	0	0
2025	4	21	0	13	9	26	0	0	0	0	0	0	0	59.67	0	0
2025	4	21	0	23	9	26	0	0	0	0	0	0	0	59.58	0	0
2025	4	21	0	33	9	27	0	0	0	0	0	0	0	59.47	0	0
2025	4	21	0	43	9	26	0	0	0	0	0	0	0	59.38	0	0
2025	4	21	0	53	9	27	0	0	0	0	0	0	0	59.29	0	0
2025	4	21	1	3	9	27	0	0	0	0	0	0	0	59.22	0	0
2025	4	21	1	13	9	27	0	0	0	0	0	0	0	59.11	0	0
2025	4	21	1	23	9	27	0	0	0	0	0	0	0	59.04	0	0
2025	4	21	1	33	9	26	0	0	0	0	0	0	0	58.95	0	0
2025	4	21	1	43	9	27	0	0	0	0	0	0	0	58.87	0	0
2025	4	21	1	53	9	27	0	0	0	0	0	0	0	58.78	0	0
2025	4	21	2	3	9	26	0	0	0	0	0	0	0	58.69	0	0
2025	4	21	2	13	9	27	0	0	0	0	0	0	0	58.62	0	0
2025	4	21	2	23	9	27	0	0	0	0	0	0	0	58.55	0	0
2025	4	21	2	33	9	27	0	0	0	0	0	0	0	58.46	0	0
2025	4	21	2	43	9	27	0	0	0	0	0	0	0	58.41	0	0
2025	4	21	2	53	9	27	0	0	0	0	0	0	0	58.32	0	0
2025	4	21	3	3	9	26	0	0	0	0	0	0	0	58.24	0	0
2025	4	21	3	13	9	27	0	0	0	0	0	0	0	58.17	0	0
2025	4	21	3	23	9	26	0	0	0	0	0	0	0	58.1	0	0
2025	4	21	3	33	9	26	0	0	0	0	0	0	0	58.03	0	0
2025	4	21	3	43	9	26	0	0	0	0	0	0	0	57.96	0	0
2025	4	21	3	53	9	26	0	0	0	0	0	0	0	57.88	0	0
2025	4	21	4	3	9	27	0	0	0	0	0	0	0	57.81	0	0
2025	4	21	4	13	9	26	0	0	0	0	0	0	0	57.74	0	0
2025	4	21	4	23	9	27	0	0	0	0	0	0	0	57.67	0	0
2025	4	21	4	33	9	26	0	0	0	0	0	0	0	57.61	0	0
2025	4	21	4	43	9	26	0	0	0	0	0	0	0	57.54	0	0
2025	4	21	4	53	9	27	0	0	0	0	0	0	0	57.47	0	0
2025	4	21	5	3	9	27	0	0	0	0	0	0	0	57.42	0	0
2025	4	21	5	13	9	27	0	0	0	0	0	0	0	57.34	0	0
2025	4	21	5	23	9	27	0	0	0	0	0	0	0	57.27	0	0
2025	4	21	5	33	9	27	0	0	0	0	0	0	0	57.2	0	0
2025	4	21	5	43	9	26	0	0	0	0	0	0	0	57.15	0	0
2025	4	21	5	53	9	27	0	0	0	0	0	0	0	57.09	0	0
2025	4	21	6	3	9	26	0	0	0	0	0	0	0	57.02	0	0
2025	4	21	6	13	9	26	0	0	0	0	0	0	0	56.97	0	0
2025	4	21	6	23	9	26	0	0	0	0	0	0	0	56.91	0	0
2025	4	21	6	33	9	27	0	0	0	0	0	0	0	56.88	0	0
2025	4	21	6	43	9	27	0	0	0	0	0	0	0	56.88	0	0
2025	4	21	6	53	9	26	0	0	0	0	0	0	0	56.88	0	0
2025	4	21	7	3	9	26	0	0	0	0	0	0	0	56.88	0	0
2025	4	21	7	13	9	27	0	0	0	0	0	0	0	56.89	0	0
2025	4	21	7	23	9	27	0	0	0	0	0	0	0	56.91	0	0
2025	4	21	7	33	9	27	0	0	0	0	0	0	0	56.95	0	0
2025	4	21	7	43	9	26	0	0	0	0	0	0	0	57	0	0
2025	4	21	7	53	9	27	0	0	0	0	0	0	0	57.07	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	1	0	3	9	11.8	0.3	3	0.75	93	63.8714	44.6964
2025	4	1	0	13	9	11.8	0.3	3	0.74	94	63.8714	44.3044
2025	4	1	0	23	9	11.8	0.3	3	0.73	92.1	63.8714	43.5203
2025	4	1	0	33	9	11.8	0.3	3	0.77	93.2	63.8714	45.8727
2025	4	1	0	43	9	11.8	0.3	3	0.71	95.6	63.8714	42.3441
2025	4	1	0	53	9	11.8	0.3	3	0.75	97	63.8714	44.6966
2025	4	1	1	3	9	11.8	0.3	3	0.71	94	63.8714	42.1481
2025	4	1	1	13	9	11.8	0.3	3	0.71	94.2	63.8714	42.5402
2025	4	1	1	23	9	11.8	0.3	3	0.76	95	63.8714	45.0887
2025	4	1	1	33	9	11.8	0.3	3	0.69	93	63.8714	41.364
2025	4	1	1	43	9	11.8	0.3	3	0.73	94.4	63.8714	43.7165
2025	4	1	1	53	9	11.8	0.3	3	0.72	96	63.8714	42.7363
2025	4	1	2	3	9	11.8	0.3	3	0.75	95.2	63.8714	44.8928
2025	4	1	2	13	9	11.8	0.3	3	0.77	92.9	63.8714	45.873
2025	4	1	2	23	9	11.8	0.3	3	0.76	94.7	63.8714	45.4809
2025	4	1	2	33	9	11.8	0.3	3	0.69	94.9	63.8714	40.9721
2025	4	1	2	43	9	11.8	0.3	3	0.72	93.7	63.8714	42.9325
2025	4	1	2	53	9	11.8	0.3	3	0.69	94.6	63.8714	41.1682
2025	4	1	3	3	9	11.8	0.3	3	0.73	94.1	63.8714	43.5206
2025	4	1	3	13	9	11.8	0.3	3	0.74	93.3	63.8058	44.2573
2025	4	1	3	23	9	11.8	0.3	3	0.75	96	63.8714	44.5009
2025	4	1	3	33	9	11.8	0.3	3	0.73	96.2	63.8714	43.5207
2025	4	1	3	43	9	11.8	0.3	3	0.74	95.6	63.8714	44.3049
2025	4	1	3	53	9	11.8	0.3	3	0.72	94.9	63.8714	43.1287
2025	4	1	4	3	9	11.8	0.3	3	0.73	95.4	63.8714	43.5208
2025	4	1	4	13	9	11.8	0.3	3	0.74	92	63.8714	44.109
2025	4	1	4	23	9	11.8	0.3	3	0.78	94.8	63.8058	46.2158
2025	4	1	4	33	9	11.8	0.3	3	0.73	95.7	63.8714	43.1288
2025	4	1	4	43	9	11.8	0.3	3	0.71	98.2	63.8058	41.9076
2025	4	1	4	53	9	11.8	0.3	3	0.75	94	63.8714	44.6972
2025	4	1	5	3	9	11.8	0.3	3	0.75	95.5	63.8714	44.5012
2025	4	1	5	13	9	11.8	0.3	3	0.76	93.2	63.8714	45.0893
2025	4	1	5	23	9	11.8	0.3	3	0.75	95	63.8714	44.8933
2025	4	1	5	33	9	11.8	0.3	3	0.7	91.9	63.8714	41.7567
2025	4	1	5	43	9	11.8	0.3	3	0.76	93	63.8058	45.4327
2025	4	1	5	53	9	11.8	0.3	3	0.71	96.4	63.8714	42.1488
2025	4	1	6	3	9	11.8	0.3	3	0.71	94.5	63.8714	42.3449
2025	4	1	6	13	9	11.8	0.3	3	0.77	94.7	63.937	45.7266
2025	4	1	6	23	9	11.8	0.3	3	0.73	95.7	63.937	43.5679
2025	4	1	6	33	9	12	0.3	3	0.76	93.7	63.937	45.1379
2025	4	1	6	43	9	12.2	0.3	3	0.78	95.3	64.0026	46.3651
2025	4	1	6	53	9	12.6	0.3	3	0.71	91.1	63.937	42.3905
2025	4	1	7	3	9	12.8	0.3	3	0.73	96.7	63.937	43.3717
2025	4	1	7	13	9	13	0.3	3	0.77	95.4	64.0026	45.7758
2025	4	1	7	23	9	13.2	0.3	3	0.73	96.7	63.937	43.3718
2025	4	1	7	33	9	13.2	0.3	3	0.73	94.1	63.937	43.7643
2025	4	1	7	43	9	13.2	0.3	3	0.74	95.8	63.937	44.1568
2025	4	1	7	53	9	13.2	0.3	3	0.75	93.8	63.937	44.5493

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	1	8	3	9	13.4	0.3	3	0.73	93.3	63.937	43.7643
2025	4	1	8	13	9	13.6	0.3	3	0.77	94.4	63.937	46.1193
2025	4	1	8	23	9	13.8	0.3	3	0.74	93.3	63.8714	44.3054
2025	4	1	8	33	9	13.8	0.3	3	0.78	97.3	63.8714	46.0698
2025	4	1	8	43	9	13.8	0.3	3	0.73	93.9	63.8714	43.5212
2025	4	1	8	53	9	13.6	0.3	3	0.72	93.4	63.8714	42.737
2025	4	1	9	3	9	13.6	0.3	3	0.74	95.6	63.8714	44.3053
2025	4	1	9	13	9	13.4	0.3	3	0.74	94.1	63.8714	44.1092
2025	4	1	9	23	9	13.4	0.3	3	0.74	96.1	63.8058	44.0618
2025	4	1	9	33	9	13.4	0.3	3	0.73	95.4	63.8714	43.521
2025	4	1	9	43	9	13.4	0.3	3	0.74	96.9	63.8714	43.717
2025	4	1	9	53	9	13.4	0.3	3	0.73	95.7	63.8714	43.3248
2025	4	1	10	3	9	13.4	0.3	3	0.74	94.3	63.8714	44.1089
2025	4	1	10	13	9	13.4	0.3	3	0.71	95.3	63.8714	42.3445
2025	4	1	10	23	9	13.4	0.3	3	0.77	96.8	63.8714	45.8731
2025	4	1	10	33	9	13.4	0.3	3	0.73	95.7	63.8714	43.3246
2025	4	1	10	43	9	13.4	0.3	3	0.77	94.6	63.8714	46.069
2025	4	1	10	53	9	13.6	0.3	3	0.75	94.3	63.8714	44.6967
2025	4	1	11	3	9	13.8	0.3	3	0.73	94.4	63.8714	43.3244
2025	4	1	11	13	9	13.8	0.3	3	0.75	94.2	63.8714	44.8926
2025	4	1	11	23	9	13.8	0.3	3	0.77	93.2	63.8714	46.0687
2025	4	1	11	33	9	13.8	0.3	3	0.73	95.7	63.8714	43.1281
2025	4	1	11	43	9	14	0.3	3	0.7	93.5	63.8714	41.9519
2025	4	1	11	53	9	14	0.3	3	0.72	95.5	63.8714	42.5399
2025	4	1	12	3	9	14	0.3	3	0.73	92.1	63.8714	43.7161
2025	4	1	12	13	9	14	0.3	3	0.74	94.8	63.937	43.9592
2025	4	1	12	23	9	14	0.3	3	0.71	95.8	63.937	42.193
2025	4	1	12	33	9	14	0.3	3	0.77	92	63.937	45.9215
2025	4	1	12	43	9	14	0.3	3	0.76	92.2	63.937	45.529
2025	4	1	12	53	9	14.2	0.3	3	0.77	93.9	63.937	45.9214
2025	4	1	13	3	9	14.2	0.3	3	0.73	94.9	63.937	43.7627
2025	4	1	13	13	9	14	0.3	3	0.77	95.2	63.937	45.7251
2025	4	1	13	23	9	14	0.3	3	0.73	94.4	63.937	43.5664
2025	4	1	13	33	9	14.2	0.3	3	0.7	93.5	63.937	41.8002
2025	4	1	13	43	9	14.2	0.3	3	0.74	92.5	63.937	44.1551
2025	4	1	13	53	9	14	0.3	3	0.78	94.1	63.937	46.3137
2025	4	1	14	3	9	14.2	0.3	3	0.74	93.3	63.937	44.3513
2025	4	1	14	13	9	14	0.3	3	0.75	95.8	63.937	44.3512
2025	4	1	14	23	9	14	0.3	3	0.71	93.2	64.0026	42.6307
2025	4	1	14	33	9	14.2	0.3	3	0.77	93.2	64.0026	45.7739
2025	4	1	14	43	9	14.2	0.3	3	0.75	93	64.0026	44.5951
2025	4	1	14	53	9	14.2	0.3	3	0.74	95.9	64.0026	43.8093
2025	4	1	15	3	9	14.2	0.3	3	0.71	94.2	64.0026	42.4341
2025	4	1	15	13	9	14.2	0.3	3	0.72	92.9	64.0026	42.827
2025	4	1	15	23	9	14	0.3	3	0.73	92.8	64.0026	43.8092
2025	4	1	15	33	9	14.2	0.3	3	0.73	93.6	64.0026	43.6127
2025	4	1	15	43	9	14	0.3	3	0.76	95.7	64.0682	45.2327
2025	4	1	15	53	9	14	0.3	3	0.73	94.4	64.0026	43.6127

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	1	16	3	9	13.4	0.3	3	0.73	93.3	64.0026	43.8091
2025	4	1	16	13	9	13.2	0.3	3	0.73	94.7	64.0026	43.4162
2025	4	1	16	23	9	12.6	0.3	3	0.73	92.3	64.0026	43.8091
2025	4	1	16	33	9	12.4	0.3	3	0.73	94.7	64.0026	43.4161
2025	4	1	16	43	9	12.2	0.3	3	0.74	95.6	64.0026	44.3984
2025	4	1	16	53	9	12.2	0.3	3	0.76	93	64.0026	45.3807
2025	4	1	17	3	9	12.2	0.3	3	0.71	93.7	64.0026	42.6303
2025	4	1	17	13	9	12.2	0.3	3	0.73	92.1	64.0026	43.809
2025	4	1	17	23	9	12.2	0.3	3	0.71	93.5	64.0026	42.2374
2025	4	1	17	33	9	12	0.3	3	0.77	93.4	64.0026	45.9701
2025	4	1	17	43	9	12	0.3	3	0.73	92.3	64.0026	43.4162
2025	4	1	17	53	9	12	0.3	3	0.7	95.4	64.0026	41.8446
2025	4	1	18	3	9	12	0.3	3	0.79	92.1	64.0026	47.1489
2025	4	1	18	13	9	12	0.3	3	0.74	91.5	63.937	44.1548
2025	4	1	18	23	9	12	0.3	3	0.75	94.2	63.937	44.9398
2025	4	1	18	33	9	12	0.3	3	0.76	92.5	63.937	45.5286
2025	4	1	18	43	9	12	0.3	3	0.77	92.2	63.937	45.7249
2025	4	1	18	53	9	12	0.3	3	0.73	93.4	63.937	43.37
2025	4	1	19	3	9	12	0.3	3	0.75	96.8	63.937	44.5475
2025	4	1	19	13	9	12	0.3	3	0.71	91.8	63.937	42.5851
2025	4	1	19	23	9	12	0.3	3	0.74	96.1	63.937	43.9589
2025	4	1	19	33	9	12	0.3	3	0.74	94.8	63.937	44.3514
2025	4	1	19	43	9	12	0.3	3	0.68	92.5	63.937	40.6228
2025	4	1	19	53	9	12	0.3	3	0.8	95	63.937	47.4914
2025	4	1	20	3	9	12	0.3	3	0.75	93.5	63.937	44.9402
2025	4	1	20	13	9	12	0.3	3	0.71	92.6	63.8714	42.5397
2025	4	1	20	23	9	12	0.3	3	0.73	94.1	63.8714	43.7159
2025	4	1	20	33	9	12	0.3	3	0.74	92.3	63.8714	44.3041
2025	4	1	20	43	9	12	0.3	3	0.72	94.7	63.8714	43.1279
2025	4	1	20	53	9	12	0.3	3	0.71	93.4	63.8714	42.5398
2025	4	1	21	3	9	12	0.3	3	0.74	94.6	63.8714	44.3042
2025	4	1	21	13	9	12	0.3	3	0.72	92.4	63.8714	42.7359
2025	4	1	21	23	9	12	0.3	3	0.73	94.6	63.8714	43.5201
2025	4	1	21	33	9	12	0.3	3	0.76	94.2	63.8714	45.2844
2025	4	1	21	43	9	12	0.3	3	0.75	94.2	63.8714	44.8924
2025	4	1	21	53	9	12	0.3	3	0.72	93.9	63.8058	43.0818
2025	4	1	22	3	9	12	0.3	3	0.76	95.4	63.8058	45.2359
2025	4	1	22	13	9	12	0.3	3	0.73	94.6	63.8058	43.4735
2025	4	1	22	23	9	12	0.3	3	0.74	93.3	63.8058	43.8652
2025	4	1	22	33	9	12	0.3	3	0.74	93.3	63.8058	43.8652
2025	4	1	22	43	9	12	0.3	3	0.73	94.7	63.8058	43.2778
2025	4	1	22	53	9	12	0.3	3	0.72	94.4	63.8058	43.082
2025	4	1	23	3	9	12	0.3	3	0.76	95.2	63.8058	45.0403
2025	4	1	23	13	9	12	0.3	3	0.74	93.8	63.8058	44.0612
2025	4	1	23	23	9	12	0.3	3	0.78	93.1	63.8058	46.607
2025	4	1	23	33	9	12	0.3	3	0.73	96	63.7402	43.0358
2025	4	1	23	43	9	12	0.3	3	0.75	93	63.7402	44.7964
2025	4	1	23	53	9	12	0.3	3	0.7	91.9	63.8058	41.7114

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	2	0	3	9	12	0.3	3	0.75	94.2	63.8058	44.8447
2025	4	2	0	13	9	12	0.3	3	0.71	94.2	63.8058	42.4948
2025	4	2	0	23	9	12	0.3	3	0.69	93.3	63.7402	41.2755
2025	4	2	0	33	9	12	0.3	3	0.79	94.1	63.7402	46.7528
2025	4	2	0	43	9	12	0.3	3	0.71	95.8	63.7402	42.058
2025	4	2	0	53	9	12	0.3	3	0.7	93.7	63.7402	41.8624
2025	4	2	1	3	9	12	0.3	3	0.72	96.3	63.7402	42.4493
2025	4	2	1	13	9	11.8	0.3	3	0.71	96.7	63.7402	41.8625
2025	4	2	1	23	9	11.8	0.3	3	0.74	93.6	63.7402	43.8187
2025	4	2	1	33	9	11.8	0.3	3	0.72	94.7	63.6745	42.7946
2025	4	2	1	43	9	11.8	0.3	3	0.75	94.3	63.6745	44.5533
2025	4	2	1	53	9	11.8	0.3	3	0.7	94.5	63.6745	41.8176
2025	4	2	2	3	9	11.8	0.3	3	0.73	93.3	63.6745	43.5763
2025	4	2	2	13	9	11.8	0.3	3	0.68	94.9	63.6745	40.6452
2025	4	2	2	23	9	11.8	0.3	3	0.74	97.1	63.6745	43.9672
2025	4	2	2	33	9	11.8	0.3	3	0.76	95.9	63.6745	45.1397
2025	4	2	2	43	9	11.8	0.3	3	0.73	95.7	63.6745	42.9902
2025	4	2	2	53	9	11.8	0.3	3	0.74	93.8	63.6745	43.7719
2025	4	2	3	3	9	11.8	0.3	3	0.72	95.7	63.6745	42.7949
2025	4	2	3	13	9	11.8	0.3	3	0.72	93.6	63.6745	42.9903
2025	4	2	3	23	9	11.8	0.3	3	0.7	92.4	63.6745	41.6225
2025	4	2	3	33	9	11.8	0.3	3	0.71	95.1	63.6745	42.0133
2025	4	2	3	43	9	11.8	0.3	3	0.75	96.6	63.6745	44.1629
2025	4	2	3	53	9	11.8	0.3	3	0.74	93.3	63.6745	43.7721
2025	4	2	4	3	9	11.8	0.3	3	0.75	96	63.6745	44.5538
2025	4	2	4	13	9	11.8	0.3	3	0.71	95.6	63.6745	42.0135
2025	4	2	4	23	9	11.8	0.3	3	0.69	95.7	63.6745	41.0364
2025	4	2	4	33	9	11.8	0.3	3	0.74	96.9	63.6745	43.7722
2025	4	2	4	43	9	11.8	0.3	3	0.73	95.7	63.6089	42.9443
2025	4	2	4	53	9	11.8	0.3	3	0.77	95.9	63.6089	45.6772
2025	4	2	5	3	9	11.8	0.3	3	0.73	95.7	63.6089	43.3348
2025	4	2	5	13	9	11.8	0.3	3	0.73	95.7	63.6089	42.9444
2025	4	2	5	23	9	11.8	0.3	3	0.72	96.1	63.6089	42.3589
2025	4	2	5	33	9	11.8	0.3	3	0.75	98.3	63.6089	43.9205
2025	4	2	5	43	9	11.8	0.3	3	0.78	95.1	63.6089	46.0678
2025	4	2	5	53	9	11.8	0.3	3	0.73	92.1	63.6089	43.1397
2025	4	2	6	3	9	11.8	0.3	3	0.74	94.8	63.6089	44.1158
2025	4	2	6	13	9	11.8	0.3	3	0.69	96	63.6745	40.8413
2025	4	2	6	23	9	11.8	0.3	3	0.74	91.3	63.6745	44.3588
2025	4	2	6	33	9	12	0.3	3	0.75	99.5	63.6745	44.1634
2025	4	2	6	43	9	12.2	0.3	3	0.71	96.9	63.6089	41.9686
2025	4	2	6	53	9	12.4	0.3	3	0.72	96.8	63.6745	42.6001
2025	4	2	7	3	9	12.8	0.3	3	0.73	95.1	63.6745	43.5772
2025	4	2	7	13	9	12.8	0.3	3	0.72	95.2	63.7402	43.0372
2025	4	2	7	23	9	13	0.3	3	0.72	94.5	63.6745	42.6001
2025	4	2	7	33	9	13	0.3	3	0.72	96.6	63.7402	42.4504
2025	4	2	7	43	9	13.2	0.3	3	0.73	92.1	63.7402	43.6241
2025	4	2	7	53	9	13.2	0.3	3	0.7	94.3	63.7402	41.6679

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	2	8	3	9	13.2	0.3	3	0.72	96.1	63.7402	42.4503
2025	4	2	8	13	9	13.4	0.3	3	0.71	96.3	63.6745	42.2093
2025	4	2	8	23	9	13.4	0.3	3	0.72	94.5	63.7402	42.6459
2025	4	2	8	33	9	13.6	0.3	3	0.72	95.7	63.8058	42.8876
2025	4	2	8	43	9	13.8	0.3	3	0.76	92.2	63.7402	45.3846
2025	4	2	8	53	9	14	0.3	3	0.76	95	63.7402	44.9933
2025	4	2	9	3	9	14	0.3	3	0.74	92.3	63.7402	43.8195
2025	4	2	9	13	9	14	0.3	3	0.71	93.7	63.7402	42.2545
2025	4	2	9	23	9	14	0.3	3	0.71	92.9	63.7402	42.2544
2025	4	2	9	33	9	14	0.3	3	0.7	93.5	63.7402	41.4719
2025	4	2	9	43	9	14	0.3	3	0.75	96.1	63.7402	44.2105
2025	4	2	9	53	9	14.2	0.3	3	0.78	94.8	63.7402	46.3623
2025	4	2	10	3	9	14.2	0.3	3	0.72	95.8	63.8058	42.4955
2025	4	2	10	13	9	14.2	0.3	3	0.74	96.4	63.7402	43.8191
2025	4	2	10	23	9	14.2	0.3	3	0.72	92.9	63.8058	42.6912
2025	4	2	10	33	9	14.2	0.3	3	0.72	93.4	63.8058	42.6911
2025	4	2	10	43	9	14.2	0.3	3	0.75	96.3	63.7402	44.4057
2025	4	2	10	53	9	14.2	0.3	3	0.7	93.2	63.8058	41.7118
2025	4	2	11	3	9	14.2	0.3	3	0.7	94.6	63.8058	41.7117
2025	4	2	11	13	9	14.2	0.3	3	0.71	94.7	63.8058	42.4949
2025	4	2	11	23	9	14	0.3	3	0.74	94.6	63.8058	44.2573
2025	4	2	11	33	9	14	0.3	3	0.73	93.4	63.7402	43.2316
2025	4	2	11	43	9	14.2	0.3	3	0.71	95.1	63.7402	42.0578
2025	4	2	11	53	9	14.2	0.3	3	0.76	93.7	63.8058	45.2362
2025	4	2	12	3	9	14.2	0.3	3	0.75	94.8	63.8058	44.4529
2025	4	2	12	13	9	14.2	0.3	3	0.74	92.3	63.8058	43.8653
2025	4	2	12	23	9	14	0.3	3	0.76	93.2	63.8058	45.4319
2025	4	2	12	33	9	14	0.3	3	0.77	95.1	63.8058	45.8235
2025	4	2	12	43	9	14	0.3	3	0.74	96.3	63.8058	44.061
2025	4	2	12	53	9	14.2	0.3	3	0.74	92.8	63.8058	43.8652
2025	4	2	13	3	9	14.2	0.3	3	0.73	96.4	63.8714	43.5202
2025	4	2	13	13	9	14.2	0.3	3	0.75	92.5	63.8714	44.6963
2025	4	2	13	23	9	14.2	0.3	3	0.76	95.4	63.8714	45.2844
2025	4	2	13	33	9	14.2	0.3	3	0.75	93.3	63.8714	44.6963
2025	4	2	13	43	9	14.2	0.3	3	0.73	93.4	63.8714	43.52
2025	4	2	13	53	9	14.2	0.3	3	0.71	94.7	63.8714	42.5398
2025	4	2	14	3	9	14.2	0.3	3	0.73	93.6	63.937	43.7629
2025	4	2	14	13	9	14.2	0.3	3	0.72	94.2	63.937	42.7817
2025	4	2	14	23	9	14	0.3	3	0.75	93.3	63.937	44.7441
2025	4	2	14	33	9	14.2	0.3	3	0.76	93.2	63.937	45.5291
2025	4	2	14	43	9	14.2	0.3	3	0.72	92.9	63.937	42.9779
2025	4	2	14	53	9	14.2	0.3	3	0.73	94.6	63.937	43.7629
2025	4	2	15	3	9	14.2	0.3	3	0.76	95.2	63.937	45.3328
2025	4	2	15	13	9	14.2	0.3	3	0.76	96.9	63.937	45.1365
2025	4	2	15	23	9	13.8	0.3	3	0.72	95.8	63.937	42.5854
2025	4	2	15	33	9	14	0.3	3	0.76	95.4	63.937	45.3328
2025	4	2	15	43	9	14	0.3	3	0.73	94.6	63.937	43.7628
2025	4	2	15	53	9	14	0.3	3	0.76	95.4	63.937	45.3328

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	2	16	3	9	13.4	0.3	3	0.77	92.4	63.937	46.1178
2025	4	2	16	13	9	14	0.3	3	0.72	93.4	64.0026	42.8275
2025	4	2	16	23	9	14.2	0.3	3	0.77	94.4	64.0026	45.9708
2025	4	2	16	33	9	14	0.3	3	0.74	90	64.0026	44.3991
2025	4	2	16	43	9	14	0.3	3	0.73	94.6	64.0026	43.8097
2025	4	2	16	53	9	14	0.3	3	0.74	93.3	64.0026	44.3991
2025	4	2	17	3	9	14	0.3	3	0.77	96.9	64.0026	45.7743
2025	4	2	17	13	9	13	0.3	3	0.76	97.7	63.937	44.9403
2025	4	2	17	23	9	13	0.3	3	0.71	95.3	64.0026	42.631
2025	4	2	17	33	9	12.6	0.3	3	0.74	96.4	63.937	43.7629
2025	4	2	17	43	9	12.4	0.3	3	0.76	96.4	63.937	45.3328
2025	4	2	17	53	9	12.4	0.3	3	0.77	95.4	63.937	45.7253
2025	4	2	18	3	9	12.2	0.3	3	0.71	94.2	63.937	42.3892
2025	4	2	18	13	9	12.2	0.3	3	0.74	96.4	63.937	43.7629
2025	4	2	18	23	9	12.2	0.3	3	0.74	94	63.937	44.3517
2025	4	2	18	33	9	12.2	0.3	3	0.71	95	63.937	42.3892
2025	4	2	18	43	9	12.2	0.3	3	0.71	91.1	63.937	42.5855
2025	4	2	18	53	9	12.2	0.3	3	0.77	96.9	63.937	45.7255
2025	4	2	19	3	9	12.2	0.3	3	0.75	93.3	63.8714	44.6963
2025	4	2	19	13	9	12	0.3	3	0.7	92.4	63.8714	41.7558
2025	4	2	19	23	9	12	0.3	3	0.72	93.7	63.8714	42.932
2025	4	2	19	33	9	12	0.3	3	0.74	95.6	63.8714	44.1083
2025	4	2	19	43	9	12	0.3	3	0.71	92.6	63.8714	42.54
2025	4	2	19	53	9	12	0.3	3	0.74	94.3	63.8714	44.1084
2025	4	2	20	3	9	12	0.3	3	0.76	94.2	63.8714	45.4807
2025	4	2	20	13	9	12	0.3	3	0.73	95.1	63.8714	43.7164
2025	4	2	20	23	9	12	0.3	3	0.76	96.5	63.8714	44.8926
2025	4	2	20	33	9	12	0.3	3	0.74	95.6	63.8058	44.0612
2025	4	2	20	43	9	12	0.3	3	0.79	96	63.8058	46.607
2025	4	2	20	53	9	12	0.3	3	0.75	93	63.8058	44.8446
2025	4	2	21	3	9	12	0.3	3	0.71	95	63.8058	42.2989
2025	4	2	21	13	9	12	0.3	3	0.77	93.2	63.8058	45.8238
2025	4	2	21	23	9	12	0.3	3	0.73	94.4	63.8058	43.6697
2025	4	2	21	33	9	12	0.3	3	0.72	93.2	63.7402	42.6448
2025	4	2	21	43	9	12	0.3	3	0.77	96.6	63.7402	45.3835
2025	4	2	21	53	9	12	0.3	3	0.73	95.4	63.7402	43.623
2025	4	2	22	3	9	12	0.3	3	0.71	94.8	63.7402	42.2537
2025	4	2	22	13	9	12	0.3	3	0.75	94	63.7402	44.6011
2025	4	2	22	23	9	12	0.3	3	0.71	96.1	63.7402	42.2537
2025	4	2	22	33	9	12	0.3	3	0.72	97.9	63.7402	42.2538
2025	4	2	22	43	9	12	0.3	3	0.73	96.7	63.6745	42.99
2025	4	2	22	53	9	12	0.3	3	0.75	94	63.6745	44.5533
2025	4	2	23	3	9	12	0.3	3	0.73	94.7	63.6745	43.1855
2025	4	2	23	13	9	12	0.3	3	0.74	95.6	63.6745	44.1626
2025	4	2	23	23	9	12	0.3	3	0.74	96.6	63.6745	43.9672
2025	4	2	23	33	9	12	0.3	3	0.73	94.7	63.6089	43.1391
2025	4	2	23	43	9	12	0.3	3	0.71	95.3	63.6089	41.7728
2025	4	2	23	53	9	12	0.3	3	0.74	96.3	63.6089	43.92

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	3	0	3	9	12	0.3	3	0.72	94.2	63.6089	42.5536
2025	4	3	0	13	9	12	0.3	3	0.71	93.2	63.6089	42.3585
2025	4	3	0	23	9	12	0.3	3	0.69	95.2	63.6089	40.9921
2025	4	3	0	33	9	12	0.3	3	0.73	94.9	63.6089	43.1394
2025	4	3	0	43	9	12	0.3	3	0.71	95.6	63.6089	41.9682
2025	4	3	0	53	9	12	0.3	3	0.73	95.1	63.6089	43.3346
2025	4	3	1	3	9	12	0.3	3	0.69	94.4	63.6089	40.9923
2025	4	3	1	13	9	12	0.3	3	0.74	96.1	63.5433	43.678
2025	4	3	1	23	9	12	0.3	3	0.69	94.9	63.5433	41.1431
2025	4	3	1	33	9	12	0.3	3	0.69	94.1	63.5433	40.7532
2025	4	3	1	43	9	12	0.3	3	0.77	93.2	63.5433	45.628
2025	4	3	1	53	9	12	0.3	3	0.72	97.9	63.5433	42.3132
2025	4	3	2	3	9	12	0.3	3	0.72	94.2	63.5433	42.7032
2025	4	3	2	13	9	12	0.3	3	0.71	91.1	63.5433	42.1183
2025	4	3	2	23	9	11.8	0.3	3	0.7	96.7	63.5433	41.3384
2025	4	3	2	33	9	11.8	0.3	3	0.72	92.9	63.5433	42.5083
2025	4	3	2	43	9	11.8	0.3	3	0.7	94.5	63.5433	41.7284
2025	4	3	2	53	9	11.8	0.3	3	0.71	95	63.5433	42.1184
2025	4	3	3	3	9	11.8	0.3	3	0.72	98.1	63.5433	42.5084
2025	4	3	3	13	9	11.8	0.3	3	0.68	95.5	63.5433	40.3636
2025	4	3	3	23	9	11.8	0.3	3	0.72	95.7	63.5433	42.7035
2025	4	3	3	33	9	11.8	0.3	3	0.72	95	63.5433	42.7035
2025	4	3	3	43	9	11.8	0.3	3	0.72	95.5	63.5433	42.5086
2025	4	3	3	53	9	11.8	0.3	3	0.74	95.9	63.4777	43.4367
2025	4	3	4	3	9	11.8	0.3	3	0.74	95.3	63.4777	43.8263
2025	4	3	4	13	9	11.8	0.3	3	0.72	94.7	63.4777	42.8524
2025	4	3	4	23	9	11.8	0.3	3	0.71	95	63.4777	42.0733
2025	4	3	4	33	9	11.8	0.3	3	0.73	93.9	63.4777	43.242
2025	4	3	4	43	9	11.8	0.3	3	0.72	96.1	63.4777	42.2681
2025	4	3	4	53	9	11.8	0.3	3	0.71	93.2	63.4777	41.8785
2025	4	3	5	3	9	11.8	0.3	3	0.74	95.3	63.4777	44.0212
2025	4	3	5	13	9	11.8	0.3	3	0.69	93.6	63.4777	40.7099
2025	4	3	5	23	9	11.8	0.3	3	0.75	94.3	63.4777	44.216
2025	4	3	5	33	9	11.8	0.3	3	0.74	95.3	63.4777	43.8265
2025	4	3	5	43	9	11.8	0.3	3	0.69	97.9	63.4777	40.7099
2025	4	3	5	53	9	11.8	0.3	3	0.71	95.3	63.4777	42.0735
2025	4	3	6	3	9	11.8	0.3	3	0.69	93.8	63.4777	41.0995
2025	4	3	6	13	9	11.8	0.3	3	0.73	96.2	63.4777	43.2422
2025	4	3	6	23	9	11.8	0.3	3	0.71	94.2	63.4777	42.0735
2025	4	3	6	33	9	12.2	0.3	3	0.74	94.3	63.4777	43.6318
2025	4	3	6	43	9	12.4	0.3	3	0.71	97.4	63.4777	42.0735
2025	4	3	6	53	9	12.8	0.3	3	0.75	96.6	63.4777	44.0214
2025	4	3	7	3	9	13	0.3	3	0.67	93.4	63.4777	39.9309
2025	4	3	7	13	9	13.2	0.3	3	0.73	97.3	63.4777	42.8527
2025	4	3	7	23	9	13.2	0.3	3	0.73	97	63.4777	42.8527
2025	4	3	7	33	9	13.4	0.3	3	0.72	93.9	63.4777	42.8527
2025	4	3	7	43	9	13.4	0.3	3	0.73	93.4	63.4777	43.0475
2025	4	3	7	53	9	13.4	0.3	3	0.71	95.6	63.5433	41.924

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	3	8	3	9	13.4	0.3	3	0.74	94.1	63.5433	43.6789
2025	4	3	8	13	9	13.6	0.3	3	0.72	93.2	63.5433	42.5089
2025	4	3	8	23	9	13.6	0.3	3	0.7	94.6	63.5433	41.5339
2025	4	3	8	33	9	13.6	0.3	3	0.72	93.1	63.5433	42.8988
2025	4	3	8	43	9	13.6	0.3	3	0.76	96.5	63.6089	44.7019
2025	4	3	8	53	9	13.6	0.3	3	0.72	97.5	63.6089	42.7498
2025	4	3	9	3	9	13.6	0.3	3	0.73	94.4	63.6745	43.1867
2025	4	3	9	13	9	13.6	0.3	3	0.77	93.2	63.6089	45.873
2025	4	3	9	23	9	13.6	0.3	3	0.73	94.4	63.6089	43.5305
2025	4	3	9	33	9	13.6	0.3	3	0.7	96.7	63.6089	41.5784
2025	4	3	9	43	9	13.6	0.3	3	0.74	94.3	63.6745	43.7727
2025	4	3	9	53	9	14	0.3	3	0.73	95.9	63.7402	43.4285
2025	4	3	10	3	9	14.2	0.3	3	0.73	94.4	63.6745	43.1863
2025	4	3	10	13	9	14.2	0.3	3	0.73	94.9	63.6745	43.1863
2025	4	3	10	23	9	14	0.3	3	0.71	96.1	63.6745	42.0137
2025	4	3	10	33	9	14.2	0.3	3	0.75	92	63.6745	44.7494
2025	4	3	10	43	9	14.2	0.3	3	0.72	94.9	63.7402	43.0369
2025	4	3	10	53	9	14.2	0.3	3	0.76	96.2	63.8058	45.0414
2025	4	3	11	3	9	14.2	0.3	3	0.71	94.8	63.8058	42.1039
2025	4	3	11	13	9	14.2	0.3	3	0.7	96	63.8058	41.3204
2025	4	3	11	23	9	13.6	0.3	3	0.75	94.8	63.8714	44.6975
2025	4	3	11	33	9	13.6	0.3	3	0.75	94	63.8714	44.6974
2025	4	3	11	43	9	13.6	0.3	3	0.74	93.3	63.8714	44.1091
2025	4	3	11	53	9	13.6	0.3	3	0.78	95.8	63.8714	46.6576
2025	4	3	12	3	9	13.6	0.3	3	0.73	94.6	63.937	43.7638
2025	4	3	12	13	9	13.6	0.3	3	0.71	92.4	63.937	42.5862
2025	4	3	12	23	9	13.6	0.3	3	0.79	94.1	64.0026	46.9539
2025	4	3	12	33	9	13.6	0.3	3	0.75	97.2	64.0026	44.7927
2025	4	3	12	43	9	13.6	0.3	3	0.74	95.6	64.0026	44.2032
2025	4	3	12	53	9	13.6	0.3	3	0.75	97	64.0682	44.8405
2025	4	3	13	3	9	13.6	0.3	3	0.73	91	64.0682	43.8571
2025	4	3	13	13	9	13.6	0.3	3	0.73	92.3	64.1995	43.5566
2025	4	3	13	23	9	13.4	0.3	3	0.74	95.6	64.1995	44.1478
2025	4	3	13	33	9	13.4	0.3	3	0.76	96	64.2651	45.1813
2025	4	3	13	43	9	13.8	0.3	3	0.76	93.2	64.3963	45.6731
2025	4	3	13	53	9	13.4	0.3	3	0.75	93	64.3963	45.0798
2025	4	3	14	3	9	13.4	0.3	3	0.74	95.6	64.4619	44.5339
2025	4	3	14	13	9	13.4	0.3	3	0.77	93.7	64.3963	46.0682
2025	4	3	14	23	9	13.4	0.3	3	0.76	95.9	64.4619	45.7213
2025	4	3	14	33	9	13.8	0.3	3	0.74	93.5	64.5276	44.7792
2025	4	3	14	43	9	13.8	0.3	3	0.74	93.5	64.5932	44.8267
2025	4	3	14	53	9	13.8	0.3	3	0.76	95.7	64.6588	45.4699
2025	4	3	15	3	9	13.8	0.3	3	0.71	95.6	64.6588	42.69
2025	4	3	15	13	9	13.8	0.3	3	0.73	94.9	64.7244	44.3253
2025	4	3	15	23	9	13.4	0.3	3	0.71	92.9	64.7244	42.7351
2025	4	3	15	33	9	13.4	0.3	3	0.74	94.8	64.7244	44.7228
2025	4	3	15	43	9	13.4	0.3	3	0.79	92.1	64.79	48.1527
2025	4	3	15	53	9	13.8	0.3	3	0.76	92.2	64.79	46.1629

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	3	16	3	9	12.6	0.3	3	0.76	95.2	64.8557	46.0126
2025	4	3	16	13	9	12.4	0.3	3	0.76	94.2	64.8557	46.0126
2025	4	3	16	23	9	14	0.3	3	0.8	92.1	64.8557	48.602
2025	4	3	16	33	9	14	0.3	3	0.76	93.7	64.9213	46.2606
2025	4	3	16	43	9	14	0.3	3	0.79	94.1	64.9213	47.8557
2025	4	3	16	53	9	14	0.3	3	0.79	91.9	64.9869	48.1059
2025	4	3	17	3	9	13.2	0.3	3	0.77	92.2	65.0525	46.558
2025	4	3	17	13	9	12.6	0.3	3	0.78	93.8	65.1837	47.6573
2025	4	3	17	23	9	12.4	0.3	3	0.76	94.5	65.315	46.3529
2025	4	3	17	33	9	12.4	0.3	3	0.81	91.9	65.3806	49.4146
2025	4	3	17	43	9	12.2	0.3	3	0.77	93.4	65.3806	47.205
2025	4	3	17	53	9	12.2	0.3	3	0.78	90.5	65.4462	47.6566
2025	4	3	18	3	9	12.2	0.3	3	0.77	92.2	65.4462	46.8523
2025	4	3	18	13	9	12.2	0.3	3	0.78	95.5	65.5118	47.7066
2025	4	3	18	23	9	12.2	0.3	3	0.78	92.2	65.5118	48.1092
2025	4	3	18	33	9	12.2	0.3	3	0.77	92.9	65.5774	47.3535
2025	4	3	18	43	9	12.2	0.3	3	0.78	95.8	65.5774	47.958
2025	4	3	18	53	9	12.2	0.3	3	0.79	96.7	65.6431	48.4116
2025	4	3	19	3	9	12.2	0.3	3	0.79	92.1	65.6431	48.4116
2025	4	3	19	13	9	12.2	0.3	3	0.82	93.7	65.7087	50.2795
2025	4	3	19	23	9	12.2	0.3	3	0.79	93.1	65.7087	48.2602
2025	4	3	19	33	9	12.2	0.3	3	0.79	95.7	65.9055	48.8163
2025	4	3	19	43	9	12.2	0.3	3	0.78	93.1	65.9711	48.2588
2025	4	3	19	53	9	12.2	0.3	3	0.81	94	66.1024	49.7813
2025	4	3	20	3	9	12.2	0.3	3	0.79	90	66.1024	48.9686
2025	4	3	20	13	9	12.2	0.3	3	0.79	93.1	66.168	49.0194
2025	4	3	20	23	9	12.2	0.3	3	0.8	93.1	66.168	49.2228
2025	4	3	20	33	9	12.2	0.3	3	0.81	91.4	66.2336	50.0883
2025	4	3	20	43	9	12	0.3	3	0.75	91.5	66.2336	46.6269
2025	4	3	20	53	9	12	0.3	3	0.81	94.2	66.2992	50.1401
2025	4	3	21	3	9	12	0.3	3	0.81	93	66.2992	50.1402
2025	4	3	21	13	9	12	0.3	3	0.84	93.4	66.3648	52.2323
2025	4	3	21	23	9	12	0.3	3	0.82	94.8	66.4305	50.8566
2025	4	3	21	33	9	12	0.3	3	0.83	93.6	66.6273	51.6285
2025	4	3	21	43	9	12	0.3	3	0.8	93.3	66.7585	50.0923
2025	4	3	21	53	9	12	0.3	3	0.79	92.6	66.8242	49.5272
2025	4	3	22	3	9	12	0.3	3	0.84	95.6	66.8242	52.1988
2025	4	3	22	13	9	12	0.3	3	0.83	93.2	66.8898	52.2524
2025	4	3	22	23	9	12	0.3	3	0.78	95.1	66.8898	48.5495
2025	4	3	22	33	9	12	0.3	3	0.82	93.9	66.9554	51.4822
2025	4	3	22	43	9	12	0.3	3	0.83	90.9	66.9554	52.1
2025	4	3	22	53	9	12	0.3	3	0.82	93	67.021	51.7411
2025	4	3	23	3	9	12	0.3	3	0.84	92.9	67.0866	52.6194
2025	4	3	23	13	9	12	0.3	3	0.83	94.7	67.1522	52.26
2025	4	3	23	23	9	12	0.3	3	0.82	94.3	67.3491	51.7983
2025	4	3	23	33	9	12	0.3	3	0.86	94.6	67.4147	54.1325
2025	4	3	23	43	9	12	0.3	3	0.83	96.6	67.4803	51.9037
2025	4	3	23	53	9	12	0.3	3	0.82	94.8	67.5459	51.5408

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	4	0	3	9	12	0.3	3	0.86	92.6	67.5459	54.4504
2025	4	4	0	13	9	12	0.3	3	0.84	95.6	67.5459	52.7878
2025	4	4	0	23	9	12	0.3	3	0.87	94.1	67.6116	55.3378
2025	4	4	0	33	9	12	0.3	3	0.82	92.7	67.6116	52.2173
2025	4	4	0	43	9	12	0.3	3	0.84	95.6	67.6772	53.1032
2025	4	4	0	53	9	12	0.3	3	0.86	90	67.7428	54.6162
2025	4	4	1	3	9	12	0.3	3	0.87	95.8	67.8084	55.0887
2025	4	4	1	13	9	12	0.3	3	0.87	92.6	67.9396	55.4091
2025	4	4	1	23	9	12	0.3	3	0.83	92.3	68.0709	53.2162
2025	4	4	1	33	9	12	0.3	3	0.87	92.2	68.1365	55.5767
2025	4	4	1	43	9	12	0.3	3	0.88	93.8	68.2021	56.2624
2025	4	4	1	53	9	12	0.3	3	0.84	93.6	68.2021	53.7432
2025	4	4	2	3	9	12	0.3	3	0.87	92.8	68.2677	55.8986
2025	4	4	2	13	9	12	0.3	3	0.82	95.5	68.2677	52.3262
2025	4	4	2	23	9	12	0.3	3	0.9	92.3	68.3333	57.6376
2025	4	4	2	33	9	12	0.3	3	0.84	94.2	68.3333	53.8512
2025	4	4	2	43	9	12	0.3	3	0.87	91.3	68.399	56.0109
2025	4	4	2	53	9	12	0.3	3	0.88	94.1	68.5958	56.3902
2025	4	4	3	3	9	12	0.3	3.3	0.84	93.8	68.727	53.9633
2025	4	4	3	13	9	12	0.3	3.3	0.86	93.9	68.7927	55.7117
2025	4	4	3	23	9	12	0.3	3.3	0.88	92.1	68.8583	56.8274
2025	4	4	3	33	9	12	0.3	3.3	0.9	93.3	68.8583	58.3117
2025	4	4	3	43	9	11.8	0.3	3.3	0.87	93	68.9239	56.2472
2025	4	4	3	53	9	11.8	0.3	3.3	0.86	94.2	68.9239	55.1859
2025	4	4	4	3	9	11.8	0.3	3.3	0.87	93.7	68.9895	56.3031
2025	4	4	4	13	9	11.8	0.3	3.3	0.88	93	68.9895	56.728
2025	4	4	4	23	9	11.8	0.3	3.3	0.9	95	69.0551	58.0604
2025	4	4	4	33	9	11.8	0.3	3.3	0.88	93.6	69.0551	57.2097
2025	4	4	4	43	9	11.8	0.3	3.3	0.88	95.3	69.1864	56.8969
2025	4	4	4	53	9	11.8	0.3	3.3	0.9	96.1	69.3176	58.077
2025	4	4	5	3	9	11.8	0.3	3.3	0.87	91.7	69.3832	56.4246
2025	4	4	5	13	9	11.8	0.3	3.3	0.9	91.3	69.4488	58.4057
2025	4	4	5	23	9	11.8	0.3	3.3	0.92	93.7	69.5144	59.7481
2025	4	4	5	33	9	11.8	0.3	3.3	0.88	92.6	69.5801	57.6634
2025	4	4	5	43	9	11.8	0.3	3.3	0.89	93.8	69.5801	58.0921
2025	4	4	5	53	9	11.8	0.3	3.3	0.93	92.8	69.5801	60.6645
2025	4	4	6	3	9	11.8	0.3	3.3	0.91	93.1	69.6457	59.4367
2025	4	4	6	13	9	11.8	0.3	3.3	0.89	94.2	69.6457	58.1493
2025	4	4	6	23	9	12	0.3	3.3	0.96	95.3	69.7113	62.5021
2025	4	4	6	33	9	12.2	0.3	3.3	0.89	92.5	69.7113	57.9917
2025	4	4	6	43	9	12.4	0.3	3.3	0.92	92.4	69.7769	60.4135
2025	4	4	6	53	9	12.6	0.3	3.3	0.9	95.2	69.7769	58.9086
2025	4	4	7	3	9	12.8	0.3	3.3	0.92	94.3	69.8425	60.0424
2025	4	4	7	13	9	13	0.3	3.3	0.91	94.8	69.9738	59.2975
2025	4	4	7	23	9	13	0.3	3.3	0.92	93.5	69.9738	60.3756
2025	4	4	7	33	9	13	0.3	3.3	0.91	94.3	70.105	60.0615
2025	4	4	7	43	9	13	0.3	3.3	0.91	93.9	70.105	59.6294
2025	4	4	7	53	9	13.2	0.3	3.3	0.92	95.1	70.1706	60.3364

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	4	8	3	9	13.2	0.3	3.3	0.92	92.5	70.1706	60.5526
2025	4	4	8	13	9	13.2	0.3	3.3	0.92	94.3	70.2362	60.828
2025	4	4	8	23	9	13.4	0.3	3.3	0.91	93.3	70.3018	59.8038
2025	4	4	8	33	9	13.4	0.3	3.3	0.92	93.7	70.3018	60.4538
2025	4	4	8	43	9	13.6	0.3	3.3	0.88	93.8	70.3018	58.287
2025	4	4	8	53	9	13.8	0.3	3.3	0.91	91.4	70.3675	60.0788
2025	4	4	9	3	9	14	0.3	3.3	0.9	93.1	70.3675	59.2111
2025	4	4	9	13	9	13.8	0.3	3.3	0.94	94	70.4331	61.8738
2025	4	4	9	23	9	14	0.3	3.3	0.89	91.7	70.4331	59.0515
2025	4	4	9	33	9	14	0.3	3.3	0.95	94.5	70.4987	63.0203
2025	4	4	9	43	9	13.8	0.3	3.3	0.91	91.9	70.4987	60.4125
2025	4	4	9	53	9	13.6	0.3	3.3	0.94	93.8	70.4987	62.3682
2025	4	4	10	3	9	13.8	0.3	3.3	0.9	94.4	70.5643	59.6009
2025	4	4	10	13	9	14	0.3	3.3	0.9	92.1	70.5643	59.8184
2025	4	4	10	23	9	14	0.3	3.3	0.91	91.4	70.6299	60.5295
2025	4	4	10	33	9	14	0.3	3.3	0.93	93.6	70.6299	61.8358
2025	4	4	10	43	9	14	0.3	3.3	0.92	92.4	70.6955	61.2418
2025	4	4	10	53	9	13.8	0.3	3.3	0.89	92.1	70.6955	59.2802
2025	4	4	11	3	9	13.8	0.3	3.3	0.94	92.6	70.6955	62.3313
2025	4	4	11	13	9	14	0.3	3.3	0.96	92.3	70.6955	63.8569
2025	4	4	11	23	9	14	0.3	3.3	0.94	93	70.7612	62.1734
2025	4	4	11	33	9	14	0.3	3.3	0.96	93.1	70.7612	63.4823
2025	4	4	11	43	9	14	0.3	3.3	0.95	94.3	70.7612	63.2641
2025	4	4	11	53	9	14	0.3	3.3	0.97	93.9	70.7612	64.1367
2025	4	4	12	3	9	14	0.3	3.3	0.93	92.4	70.7612	61.5188
2025	4	4	12	13	9	14	0.3	3.3	0.91	94.3	70.7612	60.6462
2025	4	4	12	23	9	14	0.3	3.3	0.92	92.7	70.7612	60.8643
2025	4	4	12	33	9	14	0.3	3.3	0.93	94.6	70.7612	61.7368
2025	4	4	12	43	9	14	0.3	3.3	0.93	92.4	70.7612	61.5186
2025	4	4	12	53	9	13.8	0.3	3.3	0.93	93.4	70.7612	61.5185
2025	4	4	13	3	9	13.6	0.3	3.3	0.92	91.6	70.7612	60.864
2025	4	4	13	13	9	13.6	0.3	3.3	0.94	93.4	70.7612	62.1729
2025	4	4	13	23	9	13.6	0.3	3.3	0.94	94	70.7612	62.1728
2025	4	4	13	33	9	13.6	0.3	3.3	0.92	91.6	70.8268	61.3594
2025	4	4	13	43	9	13.6	0.3	3.3	0.9	93.1	70.7612	59.9912
2025	4	4	13	53	9	13.6	0.3	3.3	0.91	92.1	70.7612	60.4274
2025	4	4	14	3	9	13.4	0.3	3.3	0.92	94.1	70.7612	61.0818
2025	4	4	14	13	9	13.6	0.3	3.3	0.92	91.4	70.8268	61.1407
2025	4	4	14	23	9	13.6	0.3	3.3	0.92	90.4	70.7612	61.2998
2025	4	4	14	33	9	13.4	0.3	3.3	0.92	94.1	70.7612	60.8634
2025	4	4	14	43	9	13.4	0.3	3.3	0.92	91.8	70.7612	61.2997
2025	4	4	14	53	9	13.4	0.3	3.3	0.92	92.4	70.7612	61.2996
2025	4	4	15	3	9	13.4	0.3	3.3	0.91	91.9	70.6955	60.1506
2025	4	4	15	13	9	13.4	0.3	3.3	0.93	93	70.6955	61.894
2025	4	4	15	23	9	13.4	0.3	3.3	0.94	91.8	70.6955	62.5478
2025	4	4	15	33	9	13.4	0.3	3.3	0.95	93.6	70.6299	62.9227
2025	4	4	15	43	9	13.4	0.3	3.3	0.95	93	70.6299	62.9226
2025	4	4	15	53	9	13.4	0.3	3.3	0.93	92.2	70.4987	61.2796

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	4	16	3	9	13.4	0.3	3.3	0.95	92.4	70.3675	62.8957
2025	4	4	16	13	9	13.4	0.3	3.3	0.89	91.7	70.3675	58.9918
2025	4	4	16	23	9	13.4	0.3	3.3	0.93	93.4	70.3018	61.1011
2025	4	4	16	33	9	13.4	0.3	3.3	0.94	92.2	70.3018	61.7511
2025	4	4	16	43	9	13.6	0.3	3.3	0.93	94.2	70.2362	61.2581
2025	4	4	16	53	9	13.6	0.3	3.3	0.92	94.5	70.1706	60.3335
2025	4	4	17	3	9	13.2	0.3	3.3	0.95	91	70.1706	62.496
2025	4	4	17	13	9	12.6	0.3	3.3	0.92	93.5	70.1706	60.5497
2025	4	4	17	23	9	12.4	0.3	3.3	0.91	91.5	70.105	59.6266
2025	4	4	17	33	9	12.4	0.3	3.3	0.93	92.2	70.105	61.3549
2025	4	4	17	43	9	12.2	0.3	3.3	0.93	94.2	70.0394	61.0793
2025	4	4	17	53	9	12.2	0.3	3.3	0.88	92.1	70.0394	57.8419
2025	4	4	18	3	9	12.2	0.3	3.3	0.92	92.7	69.9738	60.1572
2025	4	4	18	13	9	12.2	0.3	3.3	0.88	93	69.9081	57.9444
2025	4	4	18	23	9	12.2	0.3	3.3	0.89	94	69.8425	58.5333
2025	4	4	18	33	9	12.2	0.3	3.3	0.89	93.6	69.7113	58.4187
2025	4	4	18	43	9	12.2	0.3	3.3	0.88	93	69.5144	57.6043
2025	4	4	18	53	9	12.2	0.3	3.3	0.92	91.2	69.5144	59.9599
2025	4	4	19	3	9	12.2	0.3	3.3	0.93	90.8	69.4488	60.5427
2025	4	4	19	13	9	12.2	0.3	3.3	0.9	93.1	69.3832	58.3459
2025	4	4	19	23	9	12.2	0.3	3.3	0.9	94.4	69.3832	58.3459
2025	4	4	19	33	9	12.2	0.3	3.3	0.86	94.2	69.3176	55.5128
2025	4	4	19	43	9	12.2	0.3	3.3	0.9	93.4	69.3176	58.2885
2025	4	4	19	53	9	12.2	0.3	3.3	0.87	94.6	69.252	56.098
2025	4	4	20	3	9	12.2	0.3	3.3	0.87	95.4	69.252	56.098
2025	4	4	20	13	9	12.2	0.3	3.3	0.89	93.8	69.1864	57.7473
2025	4	4	20	23	9	12.2	0.3	3.3	0.92	92.1	69.1207	59.3933
2025	4	4	20	33	9	12	0.3	3.3	0.92	94.3	69.1207	59.8191
2025	4	4	20	43	9	12	0.3	3.3	0.87	91.5	68.9895	56.0889
2025	4	4	20	53	9	12	0.3	3.3	0.9	93.1	68.9239	58.1558
2025	4	4	21	3	9	12	0.3	3.3	0.87	92.2	68.7927	56.3458
2025	4	4	21	13	9	12	0.3	3.3	0.86	91.3	68.6614	55.3881
2025	4	4	21	23	9	12	0.3	3	0.88	93.6	68.5958	56.6001
2025	4	4	21	33	9	12	0.3	3	0.88	93.2	68.5302	56.3327
2025	4	4	21	43	9	12	0.3	3	0.86	91.7	68.5302	55.2778
2025	4	4	21	53	9	12	0.3	3	0.86	91.5	68.5302	55.0669
2025	4	4	22	3	9	12	0.3	3	0.86	94.4	68.399	54.957
2025	4	4	22	13	9	12	0.3	3	0.84	93.3	68.399	54.1148
2025	4	4	22	23	9	12	0.3	3	0.83	93.2	68.399	53.062
2025	4	4	22	33	9	12	0.3	3	0.85	93.5	68.3333	54.2711
2025	4	4	22	43	9	12	0.3	3	0.87	92.6	68.3333	55.5333
2025	4	4	22	53	9	12	0.3	3	0.86	90.9	68.2677	55.2676
2025	4	4	23	3	9	12	0.3	3	0.86	93.7	68.2021	55.0023
2025	4	4	23	13	9	12	0.3	3	0.86	94.6	68.2021	54.5825
2025	4	4	23	23	9	12	0.3	3	0.84	93.6	68.1365	53.6889
2025	4	4	23	33	9	12	0.3	3	0.83	93.9	68.0709	52.5874
2025	4	4	23	43	9	12	0.3	3	0.85	92.7	67.9396	54.1545
2025	4	4	23	53	9	12	0.3	3	0.85	93.5	67.874	53.8911

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	5	0	3	9	12	0.3	3	0.86	91.8	67.7428	54.4078
2025	4	5	0	13	9	12	0.3	3	0.84	94.3	67.6772	53.1034
2025	4	5	0	23	9	12	0.3	3	0.85	92.4	67.6772	53.7282
2025	4	5	0	33	9	12	0.3	3	0.85	94.2	67.6116	53.8819
2025	4	5	0	43	9	12	0.3	3	0.87	93.7	67.6116	55.1302
2025	4	5	0	53	9	12	0.3	3	0.81	91.4	67.5459	51.5414
2025	4	5	1	3	9	12	0.3	3	0.87	91.5	67.5459	55.2823
2025	4	5	1	13	9	12	0.3	3	0.81	93.3	67.4803	50.8664
2025	4	5	1	23	9	12	0.3	3	0.84	92.7	67.4803	53.1502
2025	4	5	1	33	9	12	0.3	3	0.83	92.7	67.4147	52.4741
2025	4	5	1	43	9	12	0.3	3	0.79	90.5	67.4147	50.1926
2025	4	5	1	53	9	12	0.3	3	0.82	95	67.4147	51.6445
2025	4	5	2	3	9	12	0.3	3	0.84	92.7	67.3491	53.0425
2025	4	5	2	13	9	12	0.3	3	0.85	94.2	67.3491	53.6641
2025	4	5	2	23	9	12	0.3	3	0.83	92.5	67.3491	52.2137
2025	4	5	2	33	9	12	0.3	3	0.82	93.2	67.2835	51.9537
2025	4	5	2	43	9	12	0.3	3	0.84	94.7	67.2835	52.7817
2025	4	5	2	53	9	12	0.3	3	0.85	94.4	67.2178	53.3483
2025	4	5	3	3	9	12	0.3	3	0.81	94.9	67.2178	51.0738
2025	4	5	3	13	9	12	0.3	3	0.84	91.6	67.1522	52.6743
2025	4	5	3	23	9	12	0.3	3	0.83	93.6	67.0866	52.0016
2025	4	5	3	33	9	12	0.3	3	0.81	91.9	67.021	50.7117
2025	4	5	3	43	9	12	0.3	3	0.81	93.7	66.8898	50.8138
2025	4	5	3	53	9	11.8	0.3	3	0.82	92.7	66.8898	51.6367
2025	4	5	4	3	9	11.8	0.3	3	0.85	93.1	66.8242	53.228
2025	4	5	4	13	9	11.8	0.3	3	0.83	93.9	66.7585	51.531
2025	4	5	4	23	9	11.8	0.3	3	0.81	94.9	66.7585	50.7098
2025	4	5	4	33	9	11.8	0.3	3	0.83	93.6	66.6929	51.6832
2025	4	5	4	43	9	11.8	0.3	3	0.82	94.8	66.6929	51.2731
2025	4	5	4	53	9	11.8	0.3	3	0.81	94	66.6929	50.4527
2025	4	5	5	3	9	11.8	0.3	3	0.8	94.5	66.6929	50.0425
2025	4	5	5	13	9	11.8	0.3	3	0.84	94.7	66.6273	52.4498
2025	4	5	5	23	9	11.8	0.3	3	0.84	94.7	66.6273	52.2449
2025	4	5	5	33	9	11.8	0.3	3	0.81	92.8	66.6273	50.6059
2025	4	5	5	43	9	11.8	0.3	3	0.81	92.8	66.6273	50.8107
2025	4	5	5	53	9	11.8	0.3	3	0.86	92.4	66.6273	53.6791
2025	4	5	6	3	9	11.8	0.3	3	0.8	93.3	66.5617	49.7352
2025	4	5	6	13	9	11.8	0.3	3	0.81	92.5	66.5617	50.5539
2025	4	5	6	23	9	12	0.3	3	0.84	93.4	66.5617	52.1913
2025	4	5	6	33	9	12.2	0.3	3	0.82	94.1	66.5617	51.1679
2025	4	5	6	43	9	12.4	0.3	3	0.79	90	66.4961	49.2752
2025	4	5	6	53	9	12.8	0.3	3	0.84	92.7	66.4961	52.1376
2025	4	5	7	3	9	12.8	0.3	3	0.79	91.7	66.4961	49.4796
2025	4	5	7	13	9	13	0.3	3	0.82	93.7	66.4961	50.9109
2025	4	5	7	23	9	13	0.3	3	0.78	95.8	66.4305	48.2032
2025	4	5	7	33	9	13	0.3	3	0.78	93.6	66.4305	48.4074
2025	4	5	7	43	9	13	0.3	3	0.77	94.2	66.4305	47.7946
2025	4	5	7	53	9	13.2	0.3	3	0.82	93.4	66.4305	51.0626

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	5	8	3	9	13.2	0.3	3	0.83	96.1	66.3648	51.214
2025	4	5	8	13	9	13.2	0.3	3	0.79	96.9	66.3648	48.5615
2025	4	5	8	23	9	13.4	0.3	3	0.84	93.8	66.3648	52.2341
2025	4	5	8	33	9	13.4	0.3	3	0.83	93.9	66.2992	51.161
2025	4	5	8	43	9	13.6	0.3	3	0.79	93.6	66.3648	48.9694
2025	4	5	8	53	9	13.8	0.3	3	0.78	95.5	66.2336	48.2574
2025	4	5	9	3	9	13.8	0.3	3	0.8	94.2	66.2336	49.6827
2025	4	5	9	13	9	13.8	0.3	3	0.78	92.2	66.168	48.4108
2025	4	5	9	23	9	13.8	0.3	3	0.79	94.3	66.168	48.6142
2025	4	5	9	33	9	13.6	0.3	3	0.79	94.3	66.2336	48.868
2025	4	5	9	43	9	13.8	0.3	3	0.77	94.1	66.168	47.8004
2025	4	5	9	53	9	13.8	0.3	3	0.77	93.2	66.168	47.5969
2025	4	5	10	3	9	13.8	0.3	3	0.81	94.2	66.1024	50.1891
2025	4	5	10	13	9	13.8	0.3	3	0.85	94	66.168	52.2751
2025	4	5	10	23	9	13.8	0.3	3	0.81	93	66.1024	49.9857
2025	4	5	10	33	9	13.6	0.3	3	0.84	90.9	66.1024	51.8144
2025	4	5	10	43	9	13.6	0.3	3	0.79	96.4	66.1024	48.7664
2025	4	5	10	53	9	13.6	0.3	3	0.81	94	66.1024	49.7823
2025	4	5	11	3	9	13.8	0.3	3	0.76	93.2	66.1024	46.9375
2025	4	5	11	13	9	13.6	0.3	3	0.79	91.9	66.1024	48.7661
2025	4	5	11	23	9	13.6	0.3	3	0.77	95.1	66.1024	47.5469
2025	4	5	11	33	9	13.6	0.3	3	0.81	95.3	66.1024	49.9851
2025	4	5	11	43	9	13.6	0.3	3	0.81	94.6	66.1024	49.9849
2025	4	5	11	53	9	13.6	0.3	3	0.8	94.5	66.1024	49.1721
2025	4	5	12	3	9	13.6	0.3	3	0.82	92.7	66.1024	51.0007
2025	4	5	12	13	9	13.6	0.3	3	0.81	95.1	66.1024	49.7815
2025	4	5	12	23	9	13.8	0.3	3	0.83	93.6	66.0368	51.1506
2025	4	5	12	33	9	13.6	0.3	3	0.79	94.5	66.1024	48.5621
2025	4	5	12	43	9	13.6	0.3	3	0.81	94.4	66.0368	49.9325
2025	4	5	12	53	9	13.6	0.3	3	0.82	93.7	66.0368	50.3384
2025	4	5	13	3	9	13.6	0.3	3	0.79	91.7	65.9711	48.8667
2025	4	5	13	13	9	13.6	0.3	3	0.8	92.8	65.9711	49.4749
2025	4	5	13	23	9	13.6	0.3	3	0.77	93.2	65.9711	47.2444
2025	4	5	13	33	9	13.6	0.3	3	0.76	92.7	65.9055	46.9927
2025	4	5	13	43	9	13.4	0.3	3	0.78	92.2	65.9055	48.208
2025	4	5	13	53	9	13.4	0.3	3	0.81	92.1	65.8399	49.7765
2025	4	5	14	3	9	13.4	0.3	3	0.8	93.3	65.8399	49.1694
2025	4	5	14	13	9	13.4	0.3	3	0.79	93.6	65.8399	48.7646
2025	4	5	14	23	9	13.4	0.3	3	0.79	93.8	65.8399	48.3599
2025	4	5	14	33	9	13.4	0.3	3	0.79	95	65.8399	48.3598
2025	4	5	14	43	9	13.4	0.3	3	0.82	93.7	65.8399	50.5855
2025	4	5	14	53	9	13.4	0.3	3	0.78	91.9	65.8399	47.955
2025	4	5	15	3	9	13.4	0.3	3	0.84	95.1	65.8399	51.7994
2025	4	5	15	13	9	13.4	0.3	3	0.8	90.5	65.8399	49.1689
2025	4	5	15	23	9	13.4	0.3	3	0.77	93.7	65.8399	47.5502
2025	4	5	15	33	9	13.4	0.3	3	0.78	94.4	65.8399	47.7525
2025	4	5	15	43	9	13.4	0.3	3	0.79	93.6	65.8399	48.7641
2025	4	5	15	53	9	13.4	0.3	3	0.8	90.5	65.8399	49.5735

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	5	16	3	9	13.4	0.3	3	0.79	91.9	65.8399	48.7641
2025	4	5	16	13	9	13.4	0.3	3	0.77	90	65.8399	47.3476
2025	4	5	16	23	9	13.4	0.3	3	0.83	91.4	65.8399	51.3944
2025	4	5	16	33	9	13.4	0.3	3	0.83	94.5	65.8399	51.1921
2025	4	5	16	43	9	13.4	0.3	3	0.77	94.4	65.8399	47.1452
2025	4	5	16	53	9	13.4	0.3	3	0.76	96.9	65.8399	46.7406
2025	4	5	17	3	9	12.6	0.3	3	0.81	92.5	65.8399	49.978
2025	4	5	17	13	9	12.4	0.3	3	0.81	93	65.8399	49.7757
2025	4	5	17	23	9	12.4	0.3	3	0.83	93	65.8399	50.9897
2025	4	5	17	33	9	12.2	0.3	3	0.8	92.8	65.8399	49.5733
2025	4	5	17	43	9	12.2	0.3	3	0.81	94	65.8399	49.7757
2025	4	5	17	53	9	12.2	0.3	3	0.82	93	65.8399	50.3827
2025	4	5	18	3	9	12.2	0.3	3	0.79	93.4	65.8399	48.3593
2025	4	5	18	13	9	12.2	0.3	3	0.77	91.2	65.8399	47.7523
2025	4	5	18	23	9	12.2	0.3	3	0.81	95.1	65.8399	49.7757
2025	4	5	18	33	9	12.2	0.3	3	0.73	90	65.8399	45.1219
2025	4	5	18	43	9	12.2	0.3	3	0.76	91.2	65.8399	47.1454
2025	4	5	18	53	9	12.2	0.3	3	0.81	93	65.7743	49.724
2025	4	5	19	3	9	12.2	0.3	3	0.82	95.5	65.7743	50.5326
2025	4	5	19	13	9	12.2	0.3	3	0.76	93.2	65.7743	46.8942
2025	4	5	19	23	9	12.2	0.3	3	0.8	91.2	65.7743	49.1177
2025	4	5	19	33	9	12.2	0.3	3	0.77	93.7	65.7743	47.5007
2025	4	5	19	43	9	12.2	0.3	3	0.77	95.1	65.7743	47.2986
2025	4	5	19	53	9	12.2	0.3	3	0.79	93.1	65.7743	48.3093
2025	4	5	20	3	9	12.2	0.3	3	0.83	91.8	65.7743	50.937
2025	4	5	20	13	9	12.2	0.3	3	0.8	93.5	65.7743	49.1179
2025	4	5	20	23	9	12.2	0.3	3	0.82	93.2	65.7087	50.2783
2025	4	5	20	33	9	12	0.3	3	0.78	92.9	65.7087	48.0572
2025	4	5	20	43	9	12	0.3	3	0.76	94.7	65.7087	46.8458
2025	4	5	20	53	9	12	0.3	3	0.82	92.5	65.7087	50.4804
2025	4	5	21	3	9	12	0.3	3	0.8	94	65.7087	49.067
2025	4	5	21	13	9	12	0.3	3	0.81	91.2	65.7087	49.6728
2025	4	5	21	23	9	12	0.3	3	0.78	91	65.7087	48.2594
2025	4	5	21	33	9	12	0.3	3	0.75	94	65.6431	46.192
2025	4	5	21	43	9	12	0.3	3	0.8	90.9	65.6431	49.4195
2025	4	5	21	53	9	12	0.3	3	0.8	93.1	65.6431	48.8144
2025	4	5	22	3	9	12	0.3	3	0.79	92.9	65.6431	48.6127
2025	4	5	22	13	9	12	0.3	3	0.78	93.6	65.6431	48.0076
2025	4	5	22	23	9	12	0.3	3	0.76	94.2	65.5774	46.7486
2025	4	5	22	33	9	12	0.3	3	0.8	93.5	65.6431	49.218
2025	4	5	22	43	9	12	0.3	3	0.8	94	65.5774	48.9652
2025	4	5	22	53	9	12	0.3	3	0.77	95.1	65.5774	47.3532
2025	4	5	23	3	9	12	0.3	3	0.79	94.1	65.5774	48.3608
2025	4	5	23	13	9	12	0.3	3	0.77	93.9	65.5774	47.3534
2025	4	5	23	23	9	12	0.3	3	0.79	94.5	65.5774	48.5624
2025	4	5	23	33	9	12	0.3	3	0.77	92.2	65.5774	47.152
2025	4	5	23	43	9	12	0.3	3	0.77	94.4	65.5118	47.3041
2025	4	5	23	53	9	12	0.3	3	0.77	94.4	65.5118	47.1028

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	6	0	3	9	12	0.3	3	0.81	93.5	65.5118	49.3171
2025	4	6	0	13	9	12	0.3	3	0.75	94.5	65.5118	45.8952
2025	4	6	0	23	9	12	0.3	3	0.78	93.9	65.5118	47.5056
2025	4	6	0	33	9	12	0.3	3	0.78	92.2	65.5118	47.9082
2025	4	6	0	43	9	12	0.3	3	0.77	95.2	65.5118	46.9018
2025	4	6	0	53	9	12	0.3	3	0.78	95.3	65.4462	47.6571
2025	4	6	1	3	9	12	0.3	3	0.82	93.2	65.4462	50.0702
2025	4	6	1	13	9	12	0.3	3	0.82	95.1	65.4462	49.8692
2025	4	6	1	23	9	12	0.3	3	0.78	95.1	65.4462	47.4562
2025	4	6	1	33	9	12	0.3	3	0.78	93.1	65.4462	47.8584
2025	4	6	1	43	9	12	0.3	3	0.78	92.9	65.4462	47.8585
2025	4	6	1	53	9	12	0.3	3	0.82	93	65.4462	50.0705
2025	4	6	2	3	9	12	0.3	3	0.78	93.4	65.3806	47.6076
2025	4	6	2	13	9	12	0.3	3	0.78	92.9	65.3806	47.8086
2025	4	6	2	23	9	12	0.3	3	0.76	91.7	65.3806	46.4025
2025	4	6	2	33	9	12	0.3	3	0.79	97.4	65.3806	47.8086
2025	4	6	2	43	9	11.8	0.3	3	0.77	92.2	65.3806	47.4069
2025	4	6	2	53	9	11.8	0.3	3	0.79	95	65.3806	48.2105
2025	4	6	3	3	9	11.8	0.3	3	0.82	93	65.3806	50.0184
2025	4	6	3	13	9	11.8	0.3	3	0.79	94.3	65.3806	48.4114
2025	4	6	3	23	9	11.8	0.3	3	0.76	96.2	65.315	46.3541
2025	4	6	3	33	9	11.8	0.3	3	0.78	95.5	65.3806	47.8089
2025	4	6	3	43	9	11.8	0.3	3	0.74	95.1	65.315	45.3508
2025	4	6	3	53	9	11.8	0.3	3	0.76	93.2	65.315	46.5549
2025	4	6	4	3	9	11.8	0.3	3	0.86	94.4	65.315	52.1736
2025	4	6	4	13	9	11.8	0.3	3	0.8	94	65.315	48.9629
2025	4	6	4	23	9	11.8	0.3	3	0.75	94.3	65.315	45.7523
2025	4	6	4	33	9	11.8	0.3	3	0.77	94.2	65.315	46.9563
2025	4	6	4	43	9	11.8	0.3	3	0.76	95.2	65.315	46.1537
2025	4	6	4	53	9	11.8	0.3	3	0.79	92.6	65.315	48.5618
2025	4	6	5	3	9	11.8	0.3	3	0.79	92.4	65.315	48.3611
2025	4	6	5	13	9	11.8	0.3	3	0.8	93.1	65.315	48.7625
2025	4	6	5	23	9	11.8	0.3	3	0.77	94.2	65.315	46.9565
2025	4	6	5	33	9	11.8	0.3	3	0.78	95.3	65.315	47.7592
2025	4	6	5	43	9	11.8	0.3	3	0.76	94.5	65.2494	46.3059
2025	4	6	5	53	9	11.8	0.3	3	0.8	94	65.2494	48.9119
2025	4	6	6	3	9	11.8	0.3	3	0.78	92.7	65.2494	47.5087
2025	4	6	6	13	9	11.8	0.3	3	0.8	96.8	65.2494	48.7115
2025	4	6	6	23	9	12	0.3	3	0.75	95.3	65.2494	45.7047
2025	4	6	6	33	9	12.2	0.3	3	0.77	93.2	65.2494	46.9074
2025	4	6	6	43	9	12.4	0.3	3	0.79	94.8	65.2494	48.1102
2025	4	6	6	53	9	12.8	0.3	3	0.76	96.4	65.2494	46.1056
2025	4	6	7	3	9	13	0.3	3	0.82	95.3	65.2494	49.7139
2025	4	6	7	13	9	13.2	0.3	3	0.79	95.2	65.2494	48.1102
2025	4	6	7	23	9	13.4	0.3	3	0.82	92.3	65.2494	50.1148
2025	4	6	7	33	9	13.4	0.3	3	0.8	94	65.2494	48.5112
2025	4	6	7	43	9	13.6	0.3	3	0.76	93.5	65.2494	46.1056
2025	4	6	7	53	9	13.6	0.3	3	0.79	92.9	65.2494	48.1102

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	6	8	3	9	13.6	0.3	3	0.8	93.3	65.2494	48.7116
2025	4	6	8	13	9	13.6	0.3	3	0.78	92.9	65.2494	47.3083
2025	4	6	8	23	9	13.6	0.3	3	0.78	94.8	65.2494	47.5087
2025	4	6	8	33	9	13.6	0.3	3	0.83	95.2	65.2494	50.5156
2025	4	6	8	43	9	13.6	0.3	3	0.79	94	65.2494	48.3105
2025	4	6	8	53	9	13.4	0.3	3	0.79	93.1	65.2494	48.3104
2025	4	6	9	3	9	13.4	0.3	3	0.78	93.8	65.2494	47.709
2025	4	6	9	13	9	13.4	0.3	3	0.81	92.3	65.2494	49.513
2025	4	6	9	23	9	13.4	0.3	3	0.75	94	65.2494	45.5038
2025	4	6	9	33	9	13.4	0.3	3	0.77	92.5	65.2494	46.7065
2025	4	6	9	43	9	13.4	0.3	3	0.78	91.7	65.315	47.9595
2025	4	6	9	53	9	13.4	0.3	3	0.78	92.9	65.315	47.3574
2025	4	6	10	3	9	13.4	0.3	3	0.78	92.6	65.315	47.9593
2025	4	6	10	13	9	13.4	0.3	3	0.79	93.1	65.315	48.3605
2025	4	6	10	23	9	13.4	0.3	3	0.78	95.8	65.315	47.5578
2025	4	6	10	33	9	13.4	0.3	3	0.79	94.8	65.315	48.1597
2025	4	6	10	43	9	13.4	0.3	3	0.78	92.4	65.315	47.5576
2025	4	6	10	53	9	13.4	0.3	3	0.8	91.7	65.315	48.7615
2025	4	6	11	3	9	13.4	0.3	3	0.79	94	65.315	48.36
2025	4	6	11	13	9	13.4	0.3	3	0.74	93.1	65.315	44.9487
2025	4	6	11	23	9	13.4	0.3	3	0.77	92.2	65.315	47.3565
2025	4	6	11	33	9	13.4	0.3	3	0.81	94.4	65.315	49.3631
2025	4	6	11	43	9	13.4	0.3	3	0.78	95	65.315	47.7576
2025	4	6	11	53	9	13.4	0.3	3	0.79	93.1	65.2494	48.1084
2025	4	6	12	3	9	13.4	0.3	3	0.77	91	65.2494	46.9056
2025	4	6	12	13	9	13.4	0.3	3	0.83	92.3	65.2494	50.5136
2025	4	6	12	23	9	13.4	0.3	3	0.78	94.8	65.1837	47.4568
2025	4	6	12	33	9	13.4	0.3	3	0.78	92.4	65.1837	47.8572
2025	4	6	12	43	9	13.4	0.3	3	0.77	93.2	65.1837	46.6557
2025	4	6	12	53	9	13.4	0.3	3	0.83	91.1	65.1181	50.4071
2025	4	6	13	3	9	13.4	0.3	3	0.81	91.4	65.1837	49.6591
2025	4	6	13	13	9	13.4	0.3	3	0.74	92.3	65.1837	45.2537
2025	4	6	13	23	9	13.4	0.3	3	0.77	93.4	65.1837	46.8555
2025	4	6	13	33	9	13.4	0.3	3	0.76	93.5	65.1837	46.455
2025	4	6	13	43	9	13.2	0.3	3	0.81	93.7	65.1837	49.058
2025	4	6	13	53	9	13.2	0.3	3	0.79	91.7	65.1837	48.257
2025	4	6	14	3	9	13.2	0.3	3	0.75	93.8	65.1837	45.6538
2025	4	6	14	13	9	13.2	0.3	3	0.78	93.4	65.1837	47.4559
2025	4	6	14	23	9	13.2	0.3	3	0.74	93.5	65.1837	45.2532
2025	4	6	14	33	9	13.2	0.3	3	0.79	92.6	65.1837	48.2567
2025	4	6	14	43	9	13.2	0.3	3	0.77	92.7	65.1181	46.6057
2025	4	6	14	53	9	13.2	0.3	3	0.8	96.1	65.1837	48.4568
2025	4	6	15	3	9	13.2	0.3	3	0.8	94	65.1837	48.4568
2025	4	6	15	13	9	13.2	0.3	3	0.84	94.2	65.1837	51.26
2025	4	6	15	23	9	13.2	0.3	3	0.78	93.6	65.1837	47.4555
2025	4	6	15	33	9	13.2	0.3	3	0.77	91.2	65.1837	46.8548
2025	4	6	15	43	9	13.2	0.3	3	0.8	93	65.1837	48.8571
2025	4	6	15	53	9	13.2	0.3	3	0.79	90.9	65.1837	48.4566

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	6	16	3	9	13.2	0.3	3	0.77	94.9	65.1837	47.0549
2025	4	6	16	13	9	13.2	0.3	3	0.79	92.8	65.1837	48.4565
2025	4	6	16	23	9	13.2	0.3	3	0.79	93.6	65.1837	48.056
2025	4	6	16	33	9	13.4	0.3	3	0.79	93.8	65.1837	47.8558
2025	4	6	16	43	9	12.8	0.3	3	0.8	93.1	65.1837	48.6567
2025	4	6	16	53	9	13.4	0.3	3	0.81	93.5	65.1837	49.4576
2025	4	6	17	3	9	12.4	0.3	3	0.76	90.2	65.1837	46.2539
2025	4	6	17	13	9	12.4	0.3	3	0.8	94.9	65.1837	48.6567
2025	4	6	17	23	9	12.4	0.3	3	0.8	92.6	65.1837	48.6567
2025	4	6	17	33	9	12.2	0.3	3	0.79	93.4	65.1837	47.8558
2025	4	6	17	43	9	12.2	0.3	3	0.78	91.7	65.1837	47.4553
2025	4	6	17	53	9	12.2	0.3	3	0.75	91.5	65.1837	46.0537
2025	4	6	18	3	9	12.2	0.3	3	0.75	92.5	65.1837	45.8535
2025	4	6	18	13	9	12.2	0.3	3	0.75	93.5	65.1837	45.8535
2025	4	6	18	23	9	12.2	0.3	3	0.76	92.5	65.1837	46.4542
2025	4	6	18	33	9	12.2	0.3	3	0.78	95.6	65.1837	47.2551
2025	4	6	18	43	9	12.2	0.3	3	0.82	94.2	65.1837	49.658
2025	4	6	18	53	9	12.2	0.3	3	0.82	93.7	65.1837	49.658
2025	4	6	19	3	9	12.2	0.3	3	0.79	92.9	65.1837	47.8559
2025	4	6	19	13	9	12.2	0.3	3	0.8	93.8	65.1181	48.6057
2025	4	6	19	23	9	12.2	0.3	3	0.77	93.2	65.1181	46.6055
2025	4	6	19	33	9	12.2	0.3	3	0.8	90	65.1181	48.6058
2025	4	6	19	43	9	12.2	0.3	3	0.76	93	65.1181	46.4055
2025	4	6	19	53	9	12.2	0.3	3	0.8	92.1	65.1181	48.6058
2025	4	6	20	3	9	12.2	0.3	3	0.8	92.3	65.1181	49.0059
2025	4	6	20	13	9	12.2	0.3	3	0.76	93	65.1181	46.0056
2025	4	6	20	23	9	12.2	0.3	3	0.77	90	65.1181	47.0058
2025	4	6	20	33	9	12.2	0.3	3	0.74	95.9	65.1181	44.8055
2025	4	6	20	43	9	12.2	0.3	3	0.82	94.8	65.1181	49.8062
2025	4	6	20	53	9	12	0.3	3	0.76	91.2	65.1181	46.4058
2025	4	6	21	3	9	12	0.3	3	0.75	92.3	65.0525	45.7576
2025	4	6	21	13	9	12	0.3	3	0.8	95.9	65.0525	48.555
2025	4	6	21	23	9	12	0.3	3	0.77	93.7	65.0525	46.9565
2025	4	6	21	33	9	12	0.3	3	0.79	94.3	65.0525	47.9557
2025	4	6	21	43	9	12	0.3	3	0.8	92.6	65.0525	48.9548
2025	4	6	21	53	9	12	0.3	3	0.78	93.1	65.0525	47.3563
2025	4	6	22	3	9	12	0.3	3	0.76	93.2	65.0525	46.1575
2025	4	6	22	13	9	12	0.3	3	0.78	93.9	65.0525	47.3564
2025	4	6	22	23	9	12	0.3	3	0.78	93.6	64.9869	47.5062
2025	4	6	22	33	9	12	0.3	3	0.75	95.8	64.9869	45.1109
2025	4	6	22	43	9	12	0.3	3	0.76	93.9	64.9869	46.3086
2025	4	6	22	53	9	12	0.3	3	0.76	93.2	64.9869	46.3087
2025	4	6	23	3	9	12	0.3	3	0.77	95.1	64.9869	46.7079
2025	4	6	23	13	9	12	0.3	3	0.73	93.1	64.9869	44.1131
2025	4	6	23	23	9	12	0.3	3	0.79	92.6	64.9869	47.9057
2025	4	6	23	33	9	12	0.3	3	0.78	95.3	64.9869	47.5065
2025	4	6	23	43	9	12	0.3	3	0.79	93.6	64.9213	47.6558
2025	4	6	23	53	9	12	0.3	3	0.74	93.8	64.9213	44.6649

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	7	0	3	9	12	0.3	3	0.76	91	64.9213	46.4596
2025	4	7	0	13	9	12	0.3	3	0.77	96.4	64.9213	46.2602
2025	4	7	0	23	9	12	0.3	3	0.75	93	64.9213	45.6621
2025	4	7	0	33	9	12	0.3	3	0.76	92.2	64.9213	46.2603
2025	4	7	0	43	9	12	0.3	3	0.82	93	64.9213	49.8495
2025	4	7	0	53	9	12	0.3	3	0.8	91.6	64.9213	48.6532
2025	4	7	1	3	9	12	0.3	3	0.75	90.7	64.9213	45.8617
2025	4	7	1	13	9	12	0.3	3	0.75	95.8	64.9213	45.2635
2025	4	7	1	23	9	12	0.3	3	0.78	93.9	64.9213	47.0581
2025	4	7	1	33	9	12	0.3	3	0.78	91.7	64.9213	47.2576
2025	4	7	1	43	9	12	0.3	3	0.78	95.1	64.8557	47.0086
2025	4	7	1	53	9	12	0.3	3	0.74	92.5	64.8557	45.0167
2025	4	7	2	3	9	12	0.3	3	0.76	95.2	64.8557	46.0127
2025	4	7	2	13	9	12	0.3	3	0.74	94.8	64.8557	44.8176
2025	4	7	2	23	9	12	0.3	3	0.77	92.2	64.8557	46.6104
2025	4	7	2	33	9	12	0.3	3	0.81	92.1	64.8557	49.3991
2025	4	7	2	43	9	12	0.3	3	0.81	95.4	64.8557	48.8015
2025	4	7	2	53	9	12	0.3	3	0.8	95.2	64.8557	48.204
2025	4	7	3	3	9	12	0.3	3	0.78	94.1	64.8557	47.4073
2025	4	7	3	13	9	12	0.3	3	0.78	94.8	64.8557	47.4073
2025	4	7	3	23	9	11.8	0.3	3	0.79	93.3	64.8557	48.0049
2025	4	7	3	33	9	11.8	0.3	3	0.79	95.9	64.8557	47.8057
2025	4	7	3	43	9	11.8	0.3	3	0.77	94.4	64.8557	46.4114
2025	4	7	3	53	9	11.8	0.3	3	0.77	93.2	64.79	46.7604
2025	4	7	4	3	9	11.8	0.3	3	0.76	92	64.8557	46.4115
2025	4	7	4	13	9	11.8	0.3	3	0.75	94.5	64.8557	45.6147
2025	4	7	4	23	9	11.8	0.3	3	0.8	94.5	64.8557	48.2043
2025	4	7	4	33	9	11.8	0.3	3	0.74	93.3	64.8557	45.0172
2025	4	7	4	43	9	11.8	0.3	3	0.78	94.1	64.79	46.9595
2025	4	7	4	53	9	11.8	0.3	3	0.78	91.2	64.79	47.3575
2025	4	7	5	3	9	11.8	0.3	3	0.78	95.1	64.8557	47.0092
2025	4	7	5	13	9	11.8	0.3	3	0.77	94.4	64.79	46.3626
2025	4	7	5	23	9	11.8	0.3	3	0.79	92.6	64.79	48.1535
2025	4	7	5	33	9	11.8	0.3	3	0.78	94.6	64.79	46.9596
2025	4	7	5	43	9	11.8	0.3	3	0.77	92.4	64.79	46.7606
2025	4	7	5	53	9	11.8	0.3	3	0.79	92.6	64.79	48.1535
2025	4	7	6	3	9	11.8	0.3	3	0.76	93.2	64.79	46.1637
2025	4	7	6	13	9	12	0.3	3	0.79	94.1	64.79	47.7556
2025	4	7	6	23	9	12	0.3	3	0.77	93.2	64.79	46.7607
2025	4	7	6	33	9	12	0.3	3	0.76	94.2	64.79	45.7658
2025	4	7	6	43	9	12.2	0.3	3	0.81	93	64.79	48.9495
2025	4	7	6	53	9	12.2	0.3	3	0.75	94	64.8557	45.615
2025	4	7	7	3	9	12.2	0.3	3	0.78	91.9	64.8557	47.6069
2025	4	7	7	13	9	12.8	0.3	3	0.79	94.1	64.8557	47.6069
2025	4	7	7	23	9	13.2	0.3	3	0.81	93.3	64.8557	48.8021
2025	4	7	7	33	9	13.2	0.3	3	0.73	94.6	64.8557	44.4198
2025	4	7	7	43	9	13.2	0.3	3	0.78	92.2	64.8557	47.6069
2025	4	7	7	53	9	13.2	0.3	3	0.78	93.9	64.8557	47.0093

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	7	8	3	9	13.4	0.3	3	0.79	93.3	64.79	47.9545
2025	4	7	8	13	9	13.6	0.3	3	0.8	95.2	64.8557	48.4036
2025	4	7	8	23	9	13.6	0.3	3	0.76	93.7	64.8557	45.814
2025	4	7	8	33	9	13.6	0.3	3	0.77	92.2	64.8557	46.6108
2025	4	7	8	43	9	13.6	0.3	3	0.75	92.3	64.8557	45.6148
2025	4	7	8	53	9	13.4	0.3	3	0.81	92.8	64.8557	49.001
2025	4	7	9	3	9	13.4	0.3	3	0.76	92.5	64.8557	46.2122
2025	4	7	9	13	9	13.4	0.3	3	0.78	95.8	64.8557	47.4073
2025	4	7	9	23	9	13.4	0.3	3	0.8	94.9	64.8557	48.6024
2025	4	7	9	33	9	13.4	0.3	3	0.79	92.9	64.8557	47.6063
2025	4	7	9	43	9	13.4	0.3	3	0.77	94.4	64.8557	46.8095
2025	4	7	9	53	9	13.4	0.3	3	0.74	93.5	64.8557	45.0168
2025	4	7	10	3	9	13.4	0.3	3	0.8	94.5	64.8557	48.6021
2025	4	7	10	13	9	13.4	0.3	3	0.77	95.6	64.8557	46.8094
2025	4	7	10	23	9	13.4	0.3	3	0.8	93	64.9213	48.6534
2025	4	7	10	33	9	13.4	0.3	3	0.79	92.8	64.9213	48.2545
2025	4	7	10	43	9	13.4	0.3	3	0.79	92.9	64.9213	47.6563
2025	4	7	10	53	9	13.4	0.3	3	0.78	92.9	64.9213	47.2574
2025	4	7	11	3	9	13.4	0.3	3	0.76	92	64.9213	46.4598
2025	4	7	11	13	9	13.6	0.3	3	0.74	93	64.9213	45.0639
2025	4	7	11	23	9	13.6	0.3	3	0.75	96.3	64.9869	45.5107
2025	4	7	11	33	9	13.4	0.3	3	0.82	93.9	64.9213	49.8494
2025	4	7	11	43	9	13.4	0.3	3	0.79	94.1	64.9213	47.656
2025	4	7	11	53	9	13.4	0.3	3	0.8	93.1	64.9869	48.5046
2025	4	7	12	3	9	13.4	0.3	3	0.78	91.9	64.9869	47.5065
2025	4	7	12	13	9	13.4	0.3	3	0.81	94	64.9213	48.8522
2025	4	7	12	23	9	13.8	0.3	3	0.82	94.3	64.9869	49.9017
2025	4	7	12	33	9	13.4	0.3	3	0.73	94.4	64.9869	44.5122
2025	4	7	12	43	9	13.4	0.3	3	0.82	93.7	64.9869	49.5023
2025	4	7	12	53	9	13.4	0.3	3	0.79	93.1	64.9869	48.105
2025	4	7	13	3	9	13.4	0.3	3	0.76	93	65.0525	45.9576
2025	4	7	13	13	9	13.4	0.3	3	0.78	93.9	64.9869	47.3064
2025	4	7	13	23	9	13.4	0.3	3	0.78	94.3	65.0525	47.556
2025	4	7	13	33	9	13.2	0.3	3	0.79	95	64.9869	47.7054
2025	4	7	13	43	9	13.2	0.3	3	0.83	94.6	64.9869	50.1006
2025	4	7	13	53	9	13.2	0.3	3	0.78	94.8	64.9869	47.306
2025	4	7	14	3	9	13.2	0.3	3	0.82	91.1	65.0525	49.9534
2025	4	7	14	13	9	13.2	0.3	3	0.83	92.9	65.0525	50.5527
2025	4	7	14	23	9	13.2	0.3	3	0.81	93.7	65.0525	49.1539
2025	4	7	14	33	9	13.2	0.3	3	0.78	94.4	64.9869	47.1061
2025	4	7	14	43	9	13.2	0.3	3	0.8	92.8	65.1181	48.8055
2025	4	7	14	53	9	13.2	0.3	3	0.76	94.2	65.1181	46.4052
2025	4	7	15	3	9	13.2	0.3	3	0.77	93.9	65.0525	46.9557
2025	4	7	15	13	9	13.2	0.3	3	0.8	91.4	65.1181	49.0053
2025	4	7	15	23	9	13.2	0.3	3	0.76	93.5	65.0525	46.3562
2025	4	7	15	33	9	13.2	0.3	3	0.76	94.2	65.0525	46.1563
2025	4	7	15	43	9	13.2	0.3	3	0.79	93.6	65.0525	47.7547
2025	4	7	15	53	9	13.2	0.3	3	0.78	95.3	65.0525	47.3551

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	7	16	3	9	13.2	0.3	3	0.78	92.4	65.1181	47.605
2025	4	7	16	13	9	13.2	0.3	3	0.8	91.4	65.1181	49.0051
2025	4	7	16	23	9	13.2	0.3	3	0.81	94.2	65.1181	49.0051
2025	4	7	16	33	9	13.2	0.3	3	0.81	91.2	65.1837	49.4571
2025	4	7	16	43	9	13.2	0.3	3	0.78	90	65.1837	47.8552
2025	4	7	16	53	9	13	0.3	3	0.8	92.1	65.1181	48.605
2025	4	7	17	3	9	12.4	0.3	3	0.8	93.8	65.1837	48.6561
2025	4	7	17	13	9	12.4	0.3	3	0.77	92.2	65.1837	47.0543
2025	4	7	17	23	9	12.4	0.3	3	0.77	91	65.1837	46.854
2025	4	7	17	33	9	12.4	0.3	3	0.8	93.8	65.1181	48.605
2025	4	7	17	43	9	12.2	0.3	3	0.78	91.2	65.1181	47.6049
2025	4	7	17	53	9	12.2	0.3	3	0.77	91.7	65.1181	46.8048
2025	4	7	18	3	9	12.2	0.3	3	0.8	94.5	65.1181	48.605
2025	4	7	18	13	9	12.2	0.3	3	0.78	93.6	65.1181	47.6049
2025	4	7	18	23	9	12.2	0.3	3	0.76	91.5	65.1181	46.4048
2025	4	7	18	33	9	12.2	0.3	3	0.84	93.8	65.1181	50.8053
2025	4	7	18	43	9	12.2	0.3	3	0.8	95.4	65.1181	48.4051
2025	4	7	18	53	9	12.2	0.3	3	0.8	93.5	65.1181	48.8052
2025	4	7	19	3	9	12.2	0.3	3	0.75	94.3	65.1181	45.4048
2025	4	7	19	13	9	12.2	0.3	3	0.78	94.3	65.0525	47.3552
2025	4	7	19	23	9	12.2	0.3	3	0.79	93.1	65.0525	47.9547
2025	4	7	19	33	9	12.2	0.3	3	0.76	92	65.0525	45.9566
2025	4	7	19	43	9	12.2	0.3	3	0.76	92.7	65.0525	45.9566
2025	4	7	19	53	9	12.2	0.3	3	0.75	92.3	65.0525	45.557
2025	4	7	20	3	9	12.2	0.3	3	0.78	92.2	65.0525	47.5551
2025	4	7	20	13	9	12.2	0.3	3	0.77	92.4	65.0525	46.7559
2025	4	7	20	23	9	12.2	0.3	3	0.76	93.5	65.0525	46.3563
2025	4	7	20	33	9	12.2	0.3	3	0.76	92.5	65.0525	46.1565
2025	4	7	20	43	9	12	0.3	3	0.75	91.5	65.0525	45.5571
2025	4	7	20	53	9	12	0.3	3	0.79	92.1	65.0525	47.9549
2025	4	7	21	3	9	12	0.3	3	0.76	92.2	65.0525	45.9568
2025	4	7	21	13	9	12	0.3	3	0.77	95.2	64.9869	46.5073
2025	4	7	21	23	9	12	0.3	3	0.79	93.3	64.9869	47.9045
2025	4	7	21	33	9	12	0.3	3	0.78	93.4	64.9869	47.3057
2025	4	7	21	43	9	12	0.3	3	0.81	94.7	64.9869	48.9026
2025	4	7	21	53	9	12	0.3	3	0.76	92.5	64.9869	46.3078
2025	4	7	22	3	9	12	0.3	3	0.8	94.2	64.9869	48.703
2025	4	7	22	13	9	12	0.3	3	0.79	95.5	64.9869	48.1043
2025	4	7	22	23	9	12	0.3	3	0.77	95.1	64.9213	46.6578
2025	4	7	22	33	9	12	0.3	3	0.77	93.4	64.9213	46.6579
2025	4	7	22	43	9	12	0.3	3	0.8	95.2	64.9213	48.4524
2025	4	7	22	53	9	12	0.3	3	0.76	93.5	64.9213	46.2592
2025	4	7	23	3	9	12	0.3	3	0.79	93.8	64.9213	48.0537
2025	4	7	23	13	9	12	0.3	3	0.79	93.4	64.9213	47.655
2025	4	7	23	23	9	12	0.3	3	0.77	94.4	64.9213	46.6581
2025	4	7	23	33	9	12	0.3	3	0.76	93.5	64.9213	45.8605
2025	4	7	23	43	9	12	0.3	3	0.82	93.9	64.9213	49.4496
2025	4	7	23	53	9	12	0.3	3	0.78	93.9	64.9213	47.057

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	8	0	3	9	12	0.3	3	0.8	93.1	64.9213	48.2534
2025	4	8	0	13	9	12	0.3	3	0.77	94.4	64.8557	46.8082
2025	4	8	0	23	9	12	0.3	3	0.76	92.2	64.8557	46.0115
2025	4	8	0	33	9	12	0.3	3	0.81	92.1	64.8557	48.9993
2025	4	8	0	43	9	12	0.3	3	0.78	93.2	64.8557	47.0075
2025	4	8	0	53	9	12	0.3	3	0.77	93.4	64.8557	46.8084
2025	4	8	1	3	9	12	0.3	3	0.75	92.3	64.8557	45.215
2025	4	8	1	13	9	12	0.3	3	0.76	94.7	64.8557	45.8126
2025	4	8	1	23	9	12	0.3	3	0.78	93.4	64.8557	47.4061
2025	4	8	1	33	9	12	0.3	3	0.78	93.4	64.8557	47.0078
2025	4	8	1	43	9	12	0.3	3	0.79	93.1	64.8557	47.8046
2025	4	8	1	53	9	12	0.3	3	0.77	90	64.8557	47.0078
2025	4	8	2	3	9	12	0.3	3	0.77	92.4	64.8557	47.0079
2025	4	8	2	13	9	12	0.3	3	0.83	90	64.8557	50.1949
2025	4	8	2	23	9	12	0.3	3	0.77	94.2	64.8557	46.4104
2025	4	8	2	33	9	12	0.3	3	0.8	94	64.79	48.1522
2025	4	8	2	43	9	12	0.3	3	0.76	93.5	64.79	46.1624
2025	4	8	2	53	9	12	0.3	3	0.74	90.5	64.79	44.9686
2025	4	8	3	3	9	12	0.3	3	0.78	94.1	64.79	47.3564
2025	4	8	3	13	9	11.8	0.3	3	0.74	91.8	64.79	44.9687
2025	4	8	3	23	9	11.8	0.3	3	0.76	92	64.79	46.3615
2025	4	8	3	33	9	11.8	0.3	3	0.77	93.4	64.79	46.7595
2025	4	8	3	43	9	11.8	0.3	3	0.77	95.3	64.79	46.7595
2025	4	8	3	53	9	11.8	0.3	3	0.75	92	64.79	45.1677
2025	4	8	4	3	9	11.8	0.3	3	0.76	93.2	64.79	46.1626
2025	4	8	4	13	9	11.8	0.3	3	0.77	95.6	64.79	46.5606
2025	4	8	4	23	9	11.8	0.3	3	0.77	92.9	64.79	46.5607
2025	4	8	4	33	9	11.8	0.3	3	0.8	91.4	64.79	48.7494
2025	4	8	4	43	9	11.8	0.3	3	0.75	93	64.79	45.5658
2025	4	8	4	53	9	11.8	0.3	3	0.73	94.6	64.79	44.372
2025	4	8	5	3	9	11.8	0.3	3	0.78	93.4	64.79	46.9587
2025	4	8	5	13	9	11.8	0.3	3	0.76	93.2	64.79	45.9639
2025	4	8	5	23	9	11.8	0.3	3	0.78	94.8	64.79	47.1578
2025	4	8	5	33	9	11.8	0.3	3	0.76	94	64.79	45.9639
2025	4	8	5	43	9	11.8	0.3	3	0.76	92.7	64.79	45.9639
2025	4	8	5	53	9	11.8	0.3	3	0.77	91	64.79	46.7599
2025	4	8	6	3	9	11.8	0.3	3	0.79	94.5	64.7244	47.5055
2025	4	8	6	13	9	11.8	0.3	3	0.75	95	64.79	45.566
2025	4	8	6	23	9	11.8	0.3	3	0.78	94.1	64.7244	47.108
2025	4	8	6	33	9	12	0.3	3	0.76	93.5	64.7244	45.9154
2025	4	8	6	43	9	12	0.3	3	0.77	93.4	64.7244	46.313
2025	4	8	6	53	9	12.2	0.3	3	0.79	94.5	64.7244	47.9031
2025	4	8	7	3	9	12.4	0.3	3	0.76	93.5	64.7244	46.1143
2025	4	8	7	13	9	12.4	0.3	3	0.76	94.2	64.7244	46.1143
2025	4	8	7	23	9	12.8	0.3	3	0.73	93.6	64.7244	43.9278
2025	4	8	7	33	9	13	0.3	3	0.77	94.1	64.7244	46.7106
2025	4	8	7	43	9	13.2	0.3	3	0.76	91	64.7244	46.1143
2025	4	8	7	53	9	13.2	0.3	3	0.79	93.6	64.7244	47.5056

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	8	8	3	9	13.4	0.3	3	0.79	92.6	64.7244	47.9031
2025	4	8	8	13	9	13.4	0.3	3	0.78	93.4	64.7244	47.108
2025	4	8	8	23	9	13.4	0.3	3	0.75	95	64.7244	45.5178
2025	4	8	8	33	9	13.4	0.3	3	0.77	92.2	64.7244	46.5116
2025	4	8	8	43	9	13.4	0.3	3	0.75	94	64.79	45.168
2025	4	8	8	53	9	13.4	0.3	3	0.79	92.6	64.79	47.7546
2025	4	8	9	3	9	13.4	0.3	3	0.76	91.7	64.7244	45.9152
2025	4	8	9	13	9	13.2	0.3	3	0.79	93.6	64.79	47.5555
2025	4	8	9	23	9	13.2	0.3	3	0.76	92.5	64.79	45.9637
2025	4	8	9	33	9	13.2	0.3	3	0.76	92.7	64.79	46.1626
2025	4	8	9	43	9	13.2	0.3	3	0.8	93.1	64.79	48.1522
2025	4	8	9	53	9	13.2	0.3	3	0.76	92.7	64.79	46.1624
2025	4	8	10	3	9	13.2	0.3	3	0.78	91.5	64.79	47.1572
2025	4	8	10	13	9	13.2	0.3	3	0.77	92.2	64.79	46.3612
2025	4	8	10	23	9	13.2	0.3	3	0.78	92.9	64.7244	46.9084
2025	4	8	10	33	9	13.2	0.3	3	0.76	92.5	64.79	45.7641
2025	4	8	10	43	9	13.2	0.3	3	0.79	93.4	64.79	47.5548
2025	4	8	10	53	9	13.2	0.3	3	0.77	91.7	64.79	46.9578
2025	4	8	11	3	9	13.2	0.3	3	0.8	94.3	64.79	48.1515
2025	4	8	11	13	9	13.2	0.3	3	0.74	97.1	64.79	44.7689
2025	4	8	11	23	9	13.2	0.3	3	0.75	94.3	64.7244	45.3177
2025	4	8	11	33	9	13.2	0.3	3	0.78	94.1	64.7244	47.3053
2025	4	8	11	43	9	13.2	0.3	3	0.76	92.5	64.7244	46.1126
2025	4	8	11	53	9	13.2	0.3	3	0.79	91.4	64.79	47.9521
2025	4	8	12	3	9	13.2	0.3	3	0.81	95.3	64.7244	49.0938
2025	4	8	12	13	9	13.2	0.3	3	0.8	94.9	64.7244	48.2987
2025	4	8	12	23	9	13.2	0.3	3	0.79	93.6	64.7244	47.5036
2025	4	8	12	33	9	13.4	0.3	3	0.76	94.7	64.7244	45.9134
2025	4	8	12	43	9	13.4	0.3	3	0.75	92	64.7244	45.3171
2025	4	8	12	53	9	13.4	0.3	3	0.75	92.5	64.6588	45.4675
2025	4	8	13	3	9	13.4	0.3	3	0.78	92.4	64.7244	47.1057
2025	4	8	13	13	9	13.4	0.3	3	0.77	91.7	64.6588	46.8572
2025	4	8	13	23	9	13.4	0.3	3	0.78	94.3	64.7244	47.3043
2025	4	8	13	33	9	13.2	0.3	3	0.76	92.7	64.7244	46.1117
2025	4	8	13	43	9	13.2	0.3	3	0.8	92.8	64.7244	48.2979
2025	4	8	13	53	9	13.2	0.3	3	0.79	94.3	64.7244	47.9003
2025	4	8	14	3	9	13.2	0.3	3	0.75	90.8	64.7244	45.5152
2025	4	8	14	13	9	13.2	0.3	3	0.8	95.4	64.79	48.5478
2025	4	8	14	23	9	13	0.3	3	0.81	92.3	64.7244	48.8939
2025	4	8	14	33	9	13	0.3	3	0.78	93.4	64.79	46.9559
2025	4	8	14	43	9	13	0.3	3	0.78	96	64.79	46.9559
2025	4	8	14	53	9	13	0.3	3	0.77	94.7	64.7244	46.3099
2025	4	8	15	3	9	13	0.3	3	0.79	93.6	64.79	47.7516
2025	4	8	15	13	9	13	0.3	3	0.79	92.9	64.79	47.7516
2025	4	8	15	23	9	13	0.3	3	0.76	94.4	64.79	46.1598
2025	4	8	15	33	9	13	0.3	3	0.78	91.7	64.8557	47.4037
2025	4	8	15	43	9	13	0.3	3	0.79	93.1	64.8557	47.6028
2025	4	8	15	53	9	13	0.3	3	0.78	92.9	64.9213	47.4537

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	8	16	3	9	13.2	0.3	3	0.76	92.5	64.8557	46.2085
2025	4	8	16	13	9	13.2	0.3	3	0.77	92.7	64.8557	46.4077
2025	4	8	16	23	9	13.2	0.3	3	0.78	92.4	64.8557	47.2043
2025	4	8	16	33	9	13.2	0.3	3	0.79	93.3	64.8557	48.001
2025	4	8	16	43	9	13.2	0.3	3	0.78	92.6	64.8557	47.6027
2025	4	8	16	53	9	13	0.3	3	0.79	93.3	64.79	47.9503
2025	4	8	17	3	9	12.6	0.3	3	0.81	94.9	64.8557	49.1961
2025	4	8	17	13	9	12.4	0.3	3	0.74	92	64.79	44.9658
2025	4	8	17	23	9	12.4	0.3	3	0.81	93.5	64.79	48.7462
2025	4	8	17	33	9	12.2	0.3	3	0.76	93.5	64.79	45.7617
2025	4	8	17	43	9	12.2	0.3	3	0.78	92.7	64.79	46.9555
2025	4	8	17	53	9	12.2	0.3	3	0.79	91.7	64.79	47.7514
2025	4	8	18	3	9	12.2	0.3	3	0.78	91.2	64.79	47.1545
2025	4	8	18	13	9	12.2	0.3	3	0.79	91.4	64.79	47.9504
2025	4	8	18	23	9	12.2	0.3	3	0.8	93.5	64.79	48.3483
2025	4	8	18	33	9	12.2	0.3	3	0.77	94.6	64.79	46.7566
2025	4	8	18	43	9	12.2	0.3	3	0.81	91.2	64.79	48.9453
2025	4	8	18	53	9	12.2	0.3	3	0.75	90	64.79	45.7619
2025	4	8	19	3	9	12.2	0.3	3	0.76	93.2	64.79	46.1598
2025	4	8	19	13	9	12.2	0.3	3	0.78	94.6	64.79	46.9557
2025	4	8	19	23	9	12.2	0.3	3	0.78	94.1	64.79	47.3537
2025	4	8	19	33	9	12.2	0.3	3	0.79	91.2	64.79	47.7516
2025	4	8	19	43	9	12.2	0.3	3	0.77	91.2	64.7244	46.5086
2025	4	8	19	53	9	12.2	0.3	3	0.74	91.3	64.7244	44.5211
2025	4	8	20	3	9	12	0.3	3	0.8	93.5	64.7244	48.2975
2025	4	8	20	13	9	12	0.3	3	0.81	90.2	64.7244	49.0926
2025	4	8	20	23	9	12	0.3	3	0.77	90.7	64.7244	46.7075
2025	4	8	20	33	9	12	0.3	3	0.79	93.1	64.7244	47.5026
2025	4	8	20	43	9	12	0.3	3	0.79	94.3	64.7244	47.5026
2025	4	8	20	53	9	12	0.3	3	0.76	92.5	64.7244	45.9126
2025	4	8	21	3	9	12	0.3	3	0.77	94.6	64.7244	46.7077
2025	4	8	21	13	9	12	0.3	3	0.79	95.2	64.6588	47.8495
2025	4	8	21	23	9	12	0.3	3	0.78	90	64.7244	47.304
2025	4	8	21	33	9	12	0.3	3	0.77	92.7	64.6588	46.4598
2025	4	8	21	43	9	12	0.3	3	0.76	89.5	64.6588	46.2613
2025	4	8	21	53	9	12	0.3	3	0.8	93.3	64.6588	48.2468
2025	4	8	22	3	9	12	0.3	3	0.78	95.5	64.6588	47.0555
2025	4	8	22	13	9	12	0.3	3	0.75	94.8	64.6588	45.2687
2025	4	8	22	23	9	12	0.3	3	0.72	91.3	64.6588	43.6803
2025	4	8	22	33	9	12	0.3	3	0.77	94.2	64.5932	46.2125
2025	4	8	22	43	9	12	0.3	3	0.73	94.4	64.5932	44.2291
2025	4	8	22	53	9	12	0.3	3	0.77	93.2	64.5932	46.6092
2025	4	8	23	3	9	12	0.3	3	0.81	93.3	64.5932	48.5927
2025	4	8	23	13	9	12	0.3	3	0.75	91.5	64.5932	45.221
2025	4	8	23	23	9	12	0.3	3	0.79	92.1	64.5932	47.7994
2025	4	8	23	33	9	12	0.3	3	0.79	93.3	64.5932	47.6011
2025	4	8	23	43	9	12	0.3	3	0.77	97.9	64.5932	46.0144
2025	4	8	23	53	9	12	0.3	3	0.75	92.8	64.5932	45.2211

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	9	0	3	9	12	0.3	3	0.78	92.4	64.5932	47.0062
2025	4	9	0	13	9	12	0.3	3	0.76	91.5	64.5276	45.7676
2025	4	9	0	23	9	12	0.3	3	0.79	93.6	64.5276	47.5508
2025	4	9	0	33	9	12	0.3	3	0.78	92.2	64.5276	46.9565
2025	4	9	0	43	9	12	0.3	3	0.77	94.1	64.5276	46.5603
2025	4	9	0	53	9	12	0.3	3	0.75	93.5	64.5276	45.3716
2025	4	9	1	3	9	12	0.3	3	0.79	93.3	64.5276	47.7492
2025	4	9	1	13	9	12	0.3	3	0.75	93.5	64.5276	45.3717
2025	4	9	1	23	9	12	0.3	3	0.75	92	64.5276	45.3717
2025	4	9	1	33	9	12	0.3	3	0.79	93.4	64.5276	47.353
2025	4	9	1	43	9	12	0.3	3	0.77	95.2	64.5276	46.1643
2025	4	9	1	53	9	12	0.3	3	0.75	94.8	64.5276	44.9756
2025	4	9	2	3	9	12	0.3	3	0.73	94.1	64.5276	43.7868
2025	4	9	2	13	9	12	0.3	3	0.76	93	64.5276	45.57
2025	4	9	2	23	9	12	0.3	3	0.72	91	64.4619	43.5425
2025	4	9	2	33	9	12	0.3	3	0.77	94.9	64.5276	46.1645
2025	4	9	2	43	9	11.8	0.3	3	0.73	91.3	64.5276	43.9851
2025	4	9	2	53	9	11.8	0.3	3	0.77	96.4	64.5276	45.9664
2025	4	9	3	3	9	11.8	0.3	3	0.78	91.7	64.5276	47.1553
2025	4	9	3	13	9	11.8	0.3	3	0.76	94.2	64.5276	45.9665
2025	4	9	3	23	9	11.8	0.3	3	0.76	93	64.5276	45.9665
2025	4	9	3	33	9	11.8	0.3	3	0.76	95.7	64.5932	45.817
2025	4	9	3	43	9	11.8	0.3	3	0.75	92.8	64.6588	45.4686
2025	4	9	3	53	9	11.8	0.3	3	0.75	92.3	64.6588	45.27
2025	4	9	4	3	9	11.8	0.3	3	0.79	92.6	64.7244	47.902
2025	4	9	4	13	9	11.8	0.3	3	0.74	93.3	64.7244	44.523
2025	4	9	4	23	9	11.8	0.3	3	0.76	93	64.7244	45.7156
2025	4	9	4	33	9	11.8	0.3	3	0.77	92.2	64.79	46.9579
2025	4	9	4	43	9	11.8	0.3	3	0.78	93.6	64.79	47.3559
2025	4	9	4	53	9	11.8	0.3	3	0.75	91.2	64.79	45.7641
2025	4	9	5	3	9	11.8	0.3	3	0.78	95.3	64.79	46.958
2025	4	9	5	13	9	11.8	0.3	3	0.77	96.1	64.79	46.3611
2025	4	9	5	23	9	11.8	0.3	3	0.79	91.2	64.8557	47.8045
2025	4	9	5	33	9	11.8	0.3	3	0.8	93	64.8557	48.6012
2025	4	9	5	43	9	11.8	0.3	3	0.78	92.2	64.8557	47.4061
2025	4	9	5	53	9	11.8	0.3	3	0.81	92.8	64.8557	49.398
2025	4	9	6	3	9	11.8	0.3	3	0.74	93.5	64.8557	45.016
2025	4	9	6	13	9	11.8	0.3	3	0.74	94.3	64.9213	45.0635
2025	4	9	6	23	9	12	0.3	3	0.78	95.8	64.9213	47.4563
2025	4	9	6	33	9	12.2	0.3	3	0.74	92.3	64.9213	44.8642
2025	4	9	6	43	9	12.6	0.3	3	0.74	92.8	64.9213	44.6648
2025	4	9	6	53	9	12.8	0.3	3	0.77	92.9	64.9213	46.6588
2025	4	9	7	3	9	13	0.3	3	0.77	95.9	64.9213	46.6588
2025	4	9	7	13	9	13	0.3	3	0.78	91.2	64.9869	47.7061
2025	4	9	7	23	9	13	0.3	3	0.79	92.9	64.9869	47.7061
2025	4	9	7	33	9	13.2	0.3	3	0.78	92.2	64.9869	47.706
2025	4	9	7	43	9	13.2	0.3	3	0.77	92.4	65.0525	47.1569
2025	4	9	7	53	9	13.4	0.3	3	0.8	93.1	65.0525	48.5556

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	9	8	3	9	13.4	0.3	3	0.79	93.4	65.0525	47.7563
2025	4	9	8	13	9	13.4	0.3	3	0.8	94.7	65.1181	48.8067
2025	4	9	8	23	9	13.4	0.3	3	0.77	93.2	65.1837	47.0559
2025	4	9	8	33	9	13.4	0.3	3	0.77	95.3	65.2494	47.1053
2025	4	9	8	43	9	13.4	0.3	3	0.76	92.2	65.315	46.1514
2025	4	9	8	53	9	13.4	0.3	3	0.79	90.9	65.4462	48.6611
2025	4	9	9	3	9	13.4	0.3	3	0.78	93.6	65.5118	47.9069
2025	4	9	9	13	9	13.2	0.3	3	0.8	92.3	65.5118	49.3158
2025	4	9	9	23	9	13.2	0.3	3	0.77	93.4	65.5774	47.1508
2025	4	9	9	33	9	13.2	0.3	3	0.83	90.9	65.6431	51.0325
2025	4	9	9	43	9	13.2	0.3	3	0.77	92.2	65.6431	47.4016
2025	4	9	9	53	9	13.2	0.3	3	0.81	91.2	65.7087	49.6721
2025	4	9	10	3	9	13.2	0.3	3	0.8	92.8	65.7087	49.0663
2025	4	9	10	13	9	13.2	0.3	3	0.81	94.2	65.7743	49.9259
2025	4	9	10	23	9	13.2	0.3	3	0.78	95	65.8399	48.1568
2025	4	9	10	33	9	13.2	0.3	3	0.8	95.4	65.8399	49.1684
2025	4	9	10	43	9	13.2	0.3	3	0.78	93.8	65.8399	48.1566
2025	4	9	10	53	9	13.2	0.3	3	0.8	94.5	65.9055	49.4219
2025	4	9	11	3	9	13.2	0.3	3	0.83	92	65.9055	51.2447
2025	4	9	11	13	9	13.2	0.3	3	0.81	94.2	65.9711	49.8786
2025	4	9	11	23	9	13.2	0.3	3	0.8	92.6	65.9711	49.6757
2025	4	9	11	33	9	13.2	0.3	3	0.85	92	66.0368	52.5687
2025	4	9	11	43	9	13.2	0.3	3	0.78	95.1	66.0368	48.1033
2025	4	9	11	53	9	13.2	0.3	3	0.84	92	66.0368	52.1626
2025	4	9	12	3	9	13.2	0.3	3	0.79	92.1	66.1024	49.1689
2025	4	9	12	13	9	13.2	0.3	3	0.81	92.1	66.168	50.2367
2025	4	9	12	23	9	13.2	0.3	3	0.77	91.2	66.168	47.5926
2025	4	9	12	33	9	13.2	0.3	3	0.8	92.1	66.2336	49.8813
2025	4	9	12	43	9	13.2	0.3	3	0.82	93.2	66.2336	51.1028
2025	4	9	12	53	9	13.2	0.3	3	0.82	93.7	66.2992	50.9518
2025	4	9	13	3	9	13.2	0.3	3	0.84	92.9	66.3648	52.4324
2025	4	9	13	13	9	13.2	0.3	3	0.81	91.6	66.3648	50.5962
2025	4	9	13	23	9	13.2	0.3	3	0.84	90.7	66.4305	52.0779
2025	4	9	13	33	9	13.2	0.3	3	0.81	93.2	66.4961	50.496
2025	4	9	13	43	9	13	0.3	3	0.81	90.9	66.4961	50.7004
2025	4	9	13	53	9	13	0.3	3	0.84	92.5	66.5617	52.3897
2025	4	9	14	3	9	13	0.3	3	0.81	90	66.6273	50.395
2025	4	9	14	13	9	13	0.3	3	0.83	91.4	66.6273	52.0338
2025	4	9	14	23	9	13	0.3	3	0.84	92	66.6929	52.4973
2025	4	9	14	33	9	13	0.3	3	0.84	91.3	66.6929	52.7023
2025	4	9	14	43	9	13	0.3	3	0.86	92.6	66.7585	53.988
2025	4	9	14	53	9	13	0.3	3	0.87	92.4	66.8242	54.2488
2025	4	9	15	3	9	13	0.3	3	0.83	93.2	66.8898	52.2474
2025	4	9	15	13	9	13	0.3	3	0.83	92	66.8898	52.2473
2025	4	9	15	23	9	13	0.3	3	0.86	90.9	66.9554	53.9481
2025	4	9	15	33	9	13	0.3	3	0.87	92.6	67.021	54.4154
2025	4	9	15	43	9	13	0.3	3	0.85	92.6	67.021	53.5909
2025	4	9	15	53	9	13	0.3	3	0.86	91.8	67.021	53.797

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	9	16	3	9	13	0.3	3	0.87	93.4	67.0866	54.8836
2025	4	9	16	13	9	13	0.3	3	0.85	92.9	67.0866	53.2329
2025	4	9	16	23	9	13.2	0.3	3	0.85	91.3	67.0866	53.2329
2025	4	9	16	33	9	13.2	0.3	3	0.79	90	67.2178	49.8268
2025	4	9	16	43	9	13.2	0.3	3	0.86	90.9	67.2178	54.1686
2025	4	9	16	53	9	12.8	0.3	3	0.84	92.9	67.2835	52.982
2025	4	9	17	3	9	12.6	0.3	3	0.86	93.5	67.2835	54.0168
2025	4	9	17	13	9	12.4	0.3	3	0.84	93.1	67.2835	53.189
2025	4	9	17	23	9	12.2	0.3	3	0.82	93	67.2835	51.7402
2025	4	9	17	33	9	12.2	0.3	3	0.89	94.4	67.2835	56.0864
2025	4	9	17	43	9	12.2	0.3	3	0.85	90.9	67.2835	53.8099
2025	4	9	17	53	9	12.2	0.3	3	0.86	90.2	67.3491	54.4862
2025	4	9	18	3	9	12.2	0.3	3	0.85	92.2	67.3491	53.6575
2025	4	9	18	13	9	12.2	0.3	3	0.87	91.1	67.4803	54.8046
2025	4	9	18	23	9	12.2	0.3	3	0.89	91.9	67.4803	56.2578
2025	4	9	18	33	9	12.2	0.3	3	0.85	92.9	67.4803	53.5591
2025	4	9	18	43	9	12.2	0.3	3	0.84	93.6	67.5459	53.1979
2025	4	9	18	53	9	12.2	0.3	3	0.85	90	67.6116	54.0839
2025	4	9	19	3	9	12.2	0.3	3	0.84	92	67.6116	53.0438
2025	4	9	19	13	9	12.2	0.3	3	0.85	90.7	67.6772	53.7222
2025	4	9	19	23	9	12.2	0.3	3	0.85	90	67.7428	53.7766
2025	4	9	19	33	9	12.2	0.3	3	0.88	91.1	67.7428	55.6526
2025	4	9	19	43	9	12.2	0.3	3	0.87	92.4	67.7428	55.0273
2025	4	9	19	53	9	12.2	0.3	3	0.84	93.1	67.8084	53.6224
2025	4	9	20	3	9	12.2	0.3	3	0.87	91.9	67.8084	55.2916
2025	4	9	20	13	9	12.2	0.3	3	0.84	91.1	67.874	53.2589
2025	4	9	20	23	9	12	0.3	3	0.88	92.8	67.874	56.1829
2025	4	9	20	33	9	12	0.3	3	0.88	92.4	67.874	55.7653
2025	4	9	20	43	9	12	0.3	3	0.83	89.8	67.874	53.0501
2025	4	9	20	53	9	12	0.3	3	0.88	91.1	67.874	55.7653
2025	4	9	21	3	9	12	0.3	3	0.85	93.1	67.874	54.3034
2025	4	9	21	13	9	12	0.3	3	0.86	92.4	67.9396	54.5672
2025	4	9	21	23	9	12	0.3	3	0.86	92	67.9396	54.5673
2025	4	9	21	33	9	12	0.3	3	0.81	92.8	67.9396	51.8494
2025	4	9	21	43	9	12	0.3	3	0.86	91.7	67.9396	54.7764
2025	4	9	21	53	9	12	0.3	3	0.91	92.9	67.9396	57.9125
2025	4	9	22	3	9	12	0.3	3	0.88	91.3	68.0052	55.8781
2025	4	9	22	13	9	12	0.3	3	0.88	89.8	68.0052	55.8782
2025	4	9	22	23	9	12	0.3	3	0.85	92	68.0709	54.468
2025	4	9	22	33	9	12	0.3	3	0.88	91.1	68.1365	56.2004
2025	4	9	22	43	9	12	0.3	3	0.89	93	68.2677	56.9438
2025	4	9	22	53	9	12	0.3	3	0.87	91.7	68.2677	55.4729
2025	4	9	23	3	9	12	0.3	3	0.86	91.5	68.2677	55.2629
2025	4	9	23	13	9	12	0.3	3	0.86	91.5	68.2677	55.2629
2025	4	9	23	23	9	12	0.3	3	0.84	94.3	68.3333	53.4253
2025	4	9	23	33	9	12	0.3	3	0.91	91	68.3333	58.2631
2025	4	9	23	43	9	12	0.3	3	0.86	91.5	68.3333	54.8978
2025	4	9	23	53	9	12	0.3	3	0.86	93	68.3333	55.3185

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	10	0	3	9	12	0.3	3	0.84	93.6	68.3333	53.6358
2025	4	10	0	13	9	12	0.3	3	0.88	92.4	68.399	56.4267
2025	4	10	0	23	9	12	0.3	3	0.92	91.8	68.399	58.7428
2025	4	10	0	33	9	12	0.3	3	0.86	92.2	68.399	55.1635
2025	4	10	0	43	9	12	0.3	3	0.9	92.1	68.399	57.9007
2025	4	10	0	53	9	12	0.3	3	0.88	91.3	68.399	56.4269
2025	4	10	1	3	9	12	0.3	3	0.9	92.7	68.399	57.4797
2025	4	10	1	13	9	12	0.3	3	0.83	92.5	68.399	53.2687
2025	4	10	1	23	9	12	0.3	3	0.87	90.9	68.399	55.5848
2025	4	10	1	33	9	12	0.3	3	0.9	91.9	68.399	57.6903
2025	4	10	1	43	9	12	0.3	3	0.89	91.9	68.399	56.8482
2025	4	10	1	53	9	12	0.3	3	0.87	91.7	68.399	55.7955
2025	4	10	2	3	9	12	0.3	3	0.87	92.2	68.399	55.7955
2025	4	10	2	13	9	12	0.3	3	0.9	92.5	68.399	57.901
2025	4	10	2	23	9	12	0.3	3	0.86	92.9	68.399	54.9534
2025	4	10	2	33	9	12	0.3	3	0.88	91.1	68.4646	56.6945
2025	4	10	2	43	9	12	0.3	3	0.86	91.1	68.4646	55.43
2025	4	10	2	53	9	12	0.3	3	0.87	90	68.4646	55.8515
2025	4	10	3	3	9	11.8	0.3	3	0.86	91.3	68.4646	55.43
2025	4	10	3	13	9	11.8	0.3	3	0.87	92.2	68.4646	55.8516
2025	4	10	3	23	9	11.8	0.3	3	0.86	90.9	68.4646	55.4301
2025	4	10	3	33	9	11.8	0.3	3	0.87	90.4	68.4646	55.8516
2025	4	10	3	43	9	11.8	0.3	3	0.91	93.3	68.4646	58.17
2025	4	10	3	53	9	11.8	0.3	3	0.87	94.5	68.5302	55.6965
2025	4	10	4	3	9	11.8	0.3	3	0.87	91.1	68.5302	55.6966
2025	4	10	4	13	9	11.8	0.3	3	0.85	91.5	68.5302	54.8527
2025	4	10	4	23	9	11.8	0.3	3	0.87	91.1	68.5958	56.1746
2025	4	10	4	33	9	11.8	0.3	3	0.9	91.9	68.727	57.768
2025	4	10	4	43	9	11.8	0.3	3	0.9	89.4	68.727	57.9796
2025	4	10	4	53	9	11.8	0.3	3	0.85	92.9	68.7927	55.072
2025	4	10	5	3	9	11.8	0.3	3	0.84	92	68.7927	54.4366
2025	4	10	5	13	9	11.8	0.3	3	0.87	90.2	68.7927	56.3429
2025	4	10	5	23	9	11.8	0.3	3	0.9	94.4	68.7927	58.0375
2025	4	10	5	33	9	11.8	0.3	3	0.89	91.1	68.7927	57.1902
2025	4	10	5	43	9	11.8	0.3	3	0.86	92	68.7927	55.2839
2025	4	10	5	53	9	11.8	0.3	3	0.87	90.9	68.7927	56.343
2025	4	10	6	3	9	11.8	0.3	3	0.86	92.6	68.8583	55.763
2025	4	10	6	13	9	11.8	0.3	3	0.86	91.1	68.8583	55.763
2025	4	10	6	23	9	12	0.3	3	0.88	93.4	68.8583	56.6112
2025	4	10	6	33	9	12.2	0.3	3	0.86	92.2	68.8583	55.7631
2025	4	10	6	43	9	12.6	0.3	3	0.89	92.1	68.8583	57.2473
2025	4	10	6	53	9	12.8	0.3	3	0.86	92.8	68.8583	55.7631
2025	4	10	7	3	9	12.8	0.3	3	0.89	93.8	68.8583	57.2473
2025	4	10	7	13	9	13	0.3	3	0.92	91.2	68.8583	59.3676
2025	4	10	7	23	9	13	0.3	3	0.93	90.6	68.8583	60.0037
2025	4	10	7	33	9	13	0.3	3	0.87	90.4	68.8583	56.1872
2025	4	10	7	43	9	13.2	0.3	3	0.88	92.8	68.8583	56.6112
2025	4	10	7	53	9	13.2	0.3	3	0.9	91	68.8583	58.3074

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	10	8	3	9	13.4	0.3	3	0.88	91.7	68.9239	57.0919
2025	4	10	8	13	9	13.4	0.3	3	0.89	90.4	68.9239	57.3041
2025	4	10	8	23	9	13.2	0.3	3	0.85	90.9	68.9239	54.9694
2025	4	10	8	33	9	13.2	0.3	3	0.9	90.4	68.9239	57.9407
2025	4	10	8	43	9	13.2	0.3	3	0.9	91	68.9239	58.3651
2025	4	10	8	53	9	13.2	0.3	3	0.91	92.7	68.9239	58.5773
2025	4	10	9	3	9	13.2	0.3	3	0.88	91.3	68.9239	56.6671
2025	4	10	9	13	9	13.2	0.3	3	0.89	91.1	68.9895	57.7855
2025	4	10	9	23	9	13.2	0.3	3	0.83	93.4	68.9895	53.5365
2025	4	10	9	33	9	13.2	0.3	3	0.9	90	68.9895	58.4227
2025	4	10	9	43	9	13.2	0.3	3	0.93	93.4	68.9895	59.9098
2025	4	10	9	53	9	13.2	0.3	3	0.89	93	68.9895	57.5728
2025	4	10	10	3	9	13.2	0.3	3	0.91	92.9	68.9895	59.0598
2025	4	10	10	13	9	13.2	0.3	3	0.89	91.1	68.9895	57.3602
2025	4	10	10	23	9	13.2	0.3	3	0.94	93.4	68.9239	60.4867
2025	4	10	10	33	9	13.2	0.3	3	0.89	91.7	68.9239	57.3031
2025	4	10	10	43	9	13.2	0.3	3	0.9	90.6	68.9895	57.9972
2025	4	10	10	53	9	13.2	0.3	3	0.94	90.8	68.9895	60.5465
2025	4	10	11	3	9	13.2	0.3	3	0.88	91.1	68.9239	56.8784
2025	4	10	11	13	9	13.2	0.3	3	0.9	94.2	68.9239	58.1517
2025	4	10	11	23	9	13.2	0.3	3	0.89	91.3	68.9895	57.3596
2025	4	10	11	33	9	13.2	0.3	3	0.89	91.9	68.9895	57.3595
2025	4	10	11	43	9	13.2	0.3	3	0.89	92.5	68.9239	57.5147
2025	4	10	11	53	9	13.6	0.3	3	0.9	90.6	69.0551	58.2668
2025	4	10	12	3	9	13.6	0.3	3	0.9	90	68.9239	57.939
2025	4	10	12	13	9	13.6	0.3	3	0.89	93.6	68.9239	57.5145
2025	4	10	12	23	9	13.6	0.3	3	0.94	93.2	68.9895	60.5457
2025	4	10	12	33	9	13.6	0.3	3	0.89	91.9	68.9895	57.7838
2025	4	10	12	43	9	13.6	0.3	3	0.92	91.4	69.0551	59.5423
2025	4	10	12	53	9	13.6	0.3	3	0.9	91.9	68.9895	58.2086
2025	4	10	13	3	9	13.6	0.3	3	0.91	91.2	68.9895	58.6334
2025	4	10	13	13	9	13.6	0.3	3	0.92	91.8	69.0551	59.3294
2025	4	10	13	23	9	13.2	0.3	3	0.9	90	69.0551	58.0534
2025	4	10	13	33	9	13.2	0.3	3	0.91	91	68.9895	58.6331
2025	4	10	13	43	9	13.2	0.3	3	0.91	94.5	69.0551	59.1165
2025	4	10	13	53	9	13.2	0.3	3	0.94	90.8	69.0551	60.8176
2025	4	10	14	3	9	13.2	0.3	3	0.92	90.4	69.1207	59.6007
2025	4	10	14	13	9	13.2	0.3	3	0.92	93.3	69.1864	59.4465
2025	4	10	14	23	9	13.2	0.3	3	0.95	91.2	69.0551	61.2427
2025	4	10	14	33	9	13.2	0.3	3	0.89	92.8	69.1207	57.4719
2025	4	10	14	43	9	13.2	0.3	3	0.9	90.2	69.1207	58.5361
2025	4	10	14	53	9	13.2	0.3	3	0.9	91	69.1207	58.3232
2025	4	10	15	3	9	13.2	0.3	3	0.89	91.1	69.252	57.7988
2025	4	10	15	13	9	13.2	0.3	3	0.88	91.7	69.1207	57.046
2025	4	10	15	23	9	13.2	0.3	3	0.9	91.3	69.252	58.2253
2025	4	10	15	33	9	13.2	0.3	3	0.92	92.2	69.1207	59.8131
2025	4	10	15	43	9	13.2	0.3	3	0.94	91.8	69.252	61.2112
2025	4	10	15	53	9	13.2	0.3	3	0.93	91.2	69.1864	60.2984

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	10	16	3	9	13.2	0.3	3	0.88	91.5	69.252	57.3721
2025	4	10	16	13	9	13.2	0.3	3	0.89	90.8	69.252	57.7987
2025	4	10	16	23	9	13.2	0.3	3	0.93	94.2	69.252	60.358
2025	4	10	16	33	9	13	0.3	3	0.89	91.3	69.252	57.5854
2025	4	10	16	43	9	13.2	0.3	3	0.91	92.9	69.1864	59.233
2025	4	10	16	53	9	13	0.3	3	0.92	91	69.252	59.5049
2025	4	10	17	3	9	12.6	0.3	3	0.91	90.4	69.3176	58.9232
2025	4	10	17	13	9	12.4	0.3	3	0.93	89.4	69.3176	60.4177
2025	4	10	17	23	9	12.4	0.3	3	0.92	90.8	69.3176	59.7772
2025	4	10	17	33	9	12.4	0.3	3	0.89	92.1	69.3176	57.8558
2025	4	10	17	43	9	12.2	0.3	3	0.92	92.5	69.3832	59.8362
2025	4	10	17	53	9	12.2	0.3	3	0.89	93.6	69.3832	58.1267
2025	4	10	18	3	9	12.2	0.3	3	0.94	90	69.4488	61.6066
2025	4	10	18	13	9	12.2	0.3	3	0.9	91.7	69.4488	58.3979
2025	4	10	18	23	9	12.2	0.3	3	0.92	89.8	69.4488	60.1093
2025	4	10	18	33	9	12.2	0.3	3	0.95	92.8	69.4488	61.6067
2025	4	10	18	43	9	12.2	0.3	3	0.88	90.2	69.4488	57.3285
2025	4	10	18	53	9	12.2	0.3	3	0.87	91.1	69.4488	56.9007
2025	4	10	19	3	9	12.2	0.3	3	0.92	93.3	69.5144	60.1686
2025	4	10	19	13	9	12.2	0.3	3	0.89	94.4	69.4488	57.7564
2025	4	10	19	23	9	12.2	0.3	3	0.93	92.6	69.4488	60.5373
2025	4	10	19	33	9	12.2	0.3	3	0.92	92.5	69.4488	59.8956
2025	4	10	19	43	9	12.2	0.3	3	0.9	91.5	69.4488	58.6122
2025	4	10	19	53	9	12.2	0.3	3	0.92	91.8	69.4488	59.6818
2025	4	10	20	3	9	12.2	0.3	3	0.86	90	69.4488	56.2592
2025	4	10	20	13	9	12.2	0.3	3	0.91	90	69.4488	59.254
2025	4	10	20	23	9	12.2	0.3	3	0.92	93.3	69.4488	59.6819
2025	4	10	20	33	9	12.2	0.3	3	0.87	92.6	69.4488	56.4732
2025	4	10	20	43	9	12.2	0.3	3	0.9	90	69.4488	58.8263
2025	4	10	20	53	9	12.2	0.3	3	0.93	90.8	69.4488	60.3238
2025	4	10	21	3	9	12.2	0.3	3	0.93	90.8	69.4488	60.3238
2025	4	10	21	13	9	12.2	0.3	3	0.89	91.3	69.4488	58.1847
2025	4	10	21	23	9	12.2	0.3	3	0.89	91.1	69.4488	58.1848
2025	4	10	21	33	9	12	0.3	3	0.94	91.6	69.4488	61.1796
2025	4	10	21	43	9	12	0.3	3	0.91	91.9	69.4488	59.4683
2025	4	10	21	53	9	12	0.3	3	0.9	90.4	69.4488	58.8266
2025	4	10	22	3	9	12	0.3	3	0.91	92.7	69.4488	59.0406
2025	4	10	22	13	9	12	0.3	3	0.89	90.2	69.4488	58.185
2025	4	10	22	23	9	12	0.3	3	0.9	92.3	69.4488	58.6129
2025	4	10	22	33	9	12	0.3	3	0.89	93.4	69.4488	57.9712
2025	4	10	22	43	9	12	0.3	3	0.9	90.4	69.4488	58.8269
2025	4	10	22	53	9	12	0.3	3	0.92	90	69.4488	60.1104
2025	4	10	23	3	9	12	0.3	3	0.9	91.3	69.4488	58.613
2025	4	10	23	13	9	12	0.3	3	0.91	90.6	69.4488	59.2548
2025	4	10	23	23	9	12	0.3	3	0.92	92.9	69.3832	59.6239
2025	4	10	23	33	9	12	0.3	3	0.89	91.9	69.3832	58.128
2025	4	10	23	43	9	12	0.3	3.3	0.92	91.4	69.3832	59.624
2025	4	10	23	53	9	12	0.3	3.3	0.93	92.8	69.3832	60.4789

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	11	0	3	9	12	0.3	3.3	0.93	92.8	69.3832	60.4789
2025	4	11	0	13	9	12	0.3	3.3	0.88	90.6	69.3832	57.4871
2025	4	11	0	23	9	12	0.3	3.3	0.91	88.8	69.3832	59.1968
2025	4	11	0	33	9	12	0.3	3.3	0.9	91.9	69.3832	58.342
2025	4	11	0	43	9	12	0.3	3.3	0.91	91.9	69.3832	59.1969
2025	4	11	0	53	9	12	0.3	3.3	0.88	91.9	69.3832	57.2735
2025	4	11	1	3	9	12	0.3	3.3	0.91	91	69.3832	58.9832
2025	4	11	1	13	9	12	0.3	3.3	0.92	91.6	69.3832	59.8381
2025	4	11	1	23	9	12	0.3	3.3	0.92	92	69.3832	60.0519
2025	4	11	1	33	9	12	0.3	3.3	0.92	92.4	69.3832	60.0519
2025	4	11	1	43	9	12	0.3	3.3	0.89	91.9	69.3832	58.1286
2025	4	11	1	53	9	12	0.3	3.3	0.89	92.9	69.3832	58.1286
2025	4	11	2	3	9	12	0.3	3.3	0.92	92.5	69.3832	59.8383
2025	4	11	2	13	9	12	0.3	3.3	0.89	91.3	69.3832	57.915
2025	4	11	2	23	9	12	0.3	3.3	0.91	90	69.4488	59.2556
2025	4	11	2	33	9	12	0.3	3.3	0.88	90.6	69.4488	57.3304
2025	4	11	2	43	9	12	0.3	3.3	0.88	90.4	69.4488	57.5443
2025	4	11	2	53	9	12	0.3	3.3	0.94	91.8	69.4488	61.3949
2025	4	11	3	3	9	12	0.3	3.3	0.93	92.2	69.5144	60.5989
2025	4	11	3	13	9	12	0.3	3.3	0.89	90.6	69.5144	58.0294
2025	4	11	3	23	9	12	0.3	3.3	0.91	90.6	69.5801	59.1582
2025	4	11	3	33	9	12	0.3	3.3	0.93	90	69.5801	60.873
2025	4	11	3	43	9	12	0.3	3.3	0.92	90.8	69.5801	59.8013
2025	4	11	3	53	9	12	0.3	3.3	0.93	91.8	69.5801	60.6587
2025	4	11	4	3	9	12	0.3	3.3	0.88	91.3	69.6457	57.5001
2025	4	11	4	13	9	12	0.3	3.3	0.92	92.7	69.5801	59.8014
2025	4	11	4	23	9	12	0.3	3.3	0.87	91.1	69.5801	57.015
2025	4	11	4	33	9	11.8	0.3	3.3	0.9	92.7	69.6457	58.5729
2025	4	11	4	43	9	11.8	0.3	3.3	0.9	91	69.6457	59.0021
2025	4	11	4	53	9	11.8	0.3	3.3	0.9	91.3	69.6457	58.7875
2025	4	11	5	3	9	11.8	0.3	3.3	0.9	92.7	69.7113	58.6306
2025	4	11	5	13	9	11.8	0.3	3.3	0.97	91	69.7113	63.5702
2025	4	11	5	23	9	11.8	0.3	3.3	0.89	93.6	69.6457	57.9294
2025	4	11	5	33	9	11.8	0.3	3.3	0.93	91.4	69.7113	60.5635
2025	4	11	5	43	9	11.8	0.3	3.3	0.93	93.2	69.6457	60.5041
2025	4	11	5	53	9	11.8	0.3	3.3	0.92	92.7	69.7113	59.9193
2025	4	11	6	3	9	11.8	0.3	3.3	0.91	91.9	69.7113	59.4898
2025	4	11	6	13	9	12	0.3	3.3	0.92	93.1	69.7113	60.1341
2025	4	11	6	23	9	12.2	0.3	3.3	0.89	91.1	69.7113	58.2013
2025	4	11	6	33	9	12.4	0.3	3.3	0.89	91.5	69.6457	58.3587
2025	4	11	6	43	9	12.6	0.3	3.3	0.89	91.9	69.6457	58.1442
2025	4	11	6	53	9	12.8	0.3	3.3	0.89	92.3	69.7113	58.2013
2025	4	11	7	3	9	12.8	0.3	3.3	0.88	92.6	69.7113	57.3422
2025	4	11	7	13	9	13	0.3	3.3	0.93	92.6	69.7113	60.9932
2025	4	11	7	23	9	13	0.3	3.3	0.91	92.1	69.7113	59.4899
2025	4	11	7	33	9	13	0.3	3.3	0.93	93.6	69.7113	60.9932
2025	4	11	7	43	9	13.2	0.3	3.3	0.87	91.9	69.6457	56.8568
2025	4	11	7	53	9	13	0.3	3.3	0.89	92.5	69.7113	57.9865

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	11	8	3	9	13.2	0.3	3.3	0.89	91.7	69.7113	58.2012
2025	4	11	8	13	9	13.4	0.3	3.3	0.93	90.4	69.7113	60.5636
2025	4	11	8	23	9	13.2	0.3	3.3	0.93	91.6	69.7113	60.5635
2025	4	11	8	33	9	13.2	0.3	3.3	0.91	92.5	69.7113	59.7044
2025	4	11	8	43	9	13.2	0.3	3.3	0.9	93.7	69.7113	59.0601
2025	4	11	8	53	9	13	0.3	3.3	0.92	92	69.7113	60.1338
2025	4	11	9	3	9	13.2	0.3	3.3	0.88	92.1	69.7113	57.7714
2025	4	11	9	13	9	13.2	0.3	3.3	0.9	90	69.7113	58.8451
2025	4	11	9	23	9	13.2	0.3	3.3	0.89	90	69.7113	57.986
2025	4	11	9	33	9	13.2	0.3	3.3	0.9	91.9	69.7113	58.6302
2025	4	11	9	43	9	13.2	0.3	3.3	0.91	91.2	69.7113	59.704
2025	4	11	9	53	9	13.8	0.3	3.3	0.88	92.4	69.7113	57.3415
2025	4	11	10	3	9	13.8	0.3	3.3	0.89	92.1	69.6457	58.1433
2025	4	11	10	13	9	13.6	0.3	3.3	0.88	91.3	69.5801	57.4431
2025	4	11	10	23	9	13.8	0.3	3.3	0.88	90	69.5801	57.4431
2025	4	11	10	33	9	13.4	0.3	3.3	0.93	92	69.5801	60.4437
2025	4	11	10	43	9	13.4	0.3	3.3	0.93	93	69.5801	60.4436
2025	4	11	10	53	9	13.6	0.3	3.3	0.93	93	69.5144	60.3841
2025	4	11	11	3	9	13.4	0.3	3.3	0.93	90.6	69.5801	60.6578
2025	4	11	11	13	9	13.6	0.3	3	0.94	91.8	69.6457	61.361
2025	4	11	11	23	9	13.2	0.3	3	0.92	90.8	69.5144	60.1697
2025	4	11	11	33	9	13.2	0.3	3	0.91	93.7	69.5144	59.099
2025	4	11	11	43	9	13.2	0.3	3	0.93	91.8	69.5801	60.4431
2025	4	11	11	53	9	13.2	0.3	3	0.92	90.8	69.5801	60.0143
2025	4	11	12	3	9	13.6	0.3	3	0.93	90	69.6457	60.5023
2025	4	11	12	13	9	13.6	0.3	3	0.92	92.9	69.5801	60.2285
2025	4	11	12	23	9	13.4	0.3	3	0.96	93.7	69.7113	62.4944
2025	4	11	12	33	9	13.4	0.3	3	0.93	91.8	69.7113	60.7763
2025	4	11	12	43	9	13.4	0.3	3	0.9	89	69.5801	58.5135
2025	4	11	12	53	9	13.4	0.3	3	0.88	91.1	69.6457	57.7128
2025	4	11	13	3	9	13.4	0.3	3	0.94	90.8	69.5801	61.2997
2025	4	11	13	13	9	13.4	0.3	3	0.95	91.6	69.6457	62.0036
2025	4	11	13	23	9	13.4	0.3	3	0.92	92.3	69.6457	59.858
2025	4	11	13	33	9	13.4	0.3	3	0.92	90.8	69.6457	59.858
2025	4	11	13	43	9	13.4	0.3	3	0.95	91.6	69.7113	61.8495
2025	4	11	13	53	9	13.4	0.3	3	0.96	91.8	69.7113	62.9232
2025	4	11	14	3	9	13.4	0.3	3	0.91	92.5	69.7113	59.4871
2025	4	11	14	13	9	13.4	0.3	3	0.94	93.6	69.6457	61.145
2025	4	11	14	23	9	13.4	0.3	3	0.93	93	69.6457	60.5013
2025	4	11	14	33	9	13.4	0.3	3	0.93	89.4	69.7113	60.9902
2025	4	11	14	43	9	13.4	0.3	3	0.88	91.9	69.7113	57.5541
2025	4	11	14	53	9	13.4	0.3	3	0.91	92.3	69.6457	59.4284
2025	4	11	15	3	9	13.4	0.3	3	0.94	90.6	69.7769	61.2649
2025	4	11	15	13	9	13.4	0.3	3	0.94	92.6	69.7769	61.2648
2025	4	11	15	23	9	13.4	0.3	3	0.93	93.4	69.7769	61.0498
2025	4	11	15	33	9	13.4	0.3	3	0.92	92.1	69.7113	59.9162
2025	4	11	15	43	9	13.2	0.3	3	0.95	92.2	69.7113	61.8489
2025	4	11	15	53	9	13.2	0.3	3	0.92	90	69.7769	59.975

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	11	16	3	9	13.2	0.3	3	0.94	92.4	69.7769	61.4797
2025	4	11	16	13	9	13.2	0.3	3	0.91	91	69.8425	59.3882
2025	4	11	16	23	9	13.2	0.3	3	0.94	90	69.6457	61.5737
2025	4	11	16	33	9	13.2	0.3	3	0.93	92.8	69.7113	60.5604
2025	4	11	16	43	9	13	0.3	3	0.95	92.8	69.7113	61.8489
2025	4	11	16	53	9	12.6	0.3	3	0.91	92.7	69.7769	59.76
2025	4	11	17	3	9	12.4	0.3	3	0.92	91.8	69.8425	60.4641
2025	4	11	17	13	9	12.4	0.3	3	0.92	89	69.7769	59.975
2025	4	11	17	23	9	12.2	0.3	3	0.93	90.4	69.7769	61.0498
2025	4	11	17	33	9	12.2	0.3	3	0.91	92.1	69.7769	59.5451
2025	4	11	17	43	9	12.2	0.3	3	0.94	93.2	69.8425	61.3249
2025	4	11	17	53	9	12.2	0.3	3	0.92	92.5	69.7769	59.9751
2025	4	11	18	3	9	12.2	0.3	3	0.92	91	69.7113	59.9163
2025	4	11	18	13	9	12.2	0.3	3	0.92	90.6	69.7769	60.1901
2025	4	11	18	23	9	12.2	0.3	3	0.9	91	69.7769	58.9003
2025	4	11	18	33	9	12.2	0.3	3	0.89	90	69.7769	58.4705
2025	4	11	18	43	9	12.2	0.3	3	0.92	91.4	69.7769	59.9752
2025	4	11	18	53	9	12.2	0.3	3	0.89	93.6	69.7769	58.2556
2025	4	11	19	3	9	12.2	0.3	3	0.91	90.2	69.7769	59.7604
2025	4	11	19	13	9	12.2	0.3	3	0.88	92.1	69.7769	57.3958
2025	4	11	19	23	9	12.2	0.3	3	0.94	93.4	69.7769	61.6951
2025	4	11	19	33	9	12.2	0.3	3	0.87	92.8	69.7769	57.1809
2025	4	11	19	43	9	12.2	0.3	3	0.89	89.2	69.7769	58.2557
2025	4	11	19	53	9	12.2	0.3	3	0.92	91.2	69.7769	60.1905
2025	4	11	20	3	9	12.2	0.3	3	0.93	92.4	69.8425	61.1102
2025	4	11	20	13	9	12	0.3	3	0.89	88.1	69.8425	58.0978
2025	4	11	20	23	9	12	0.3	3	0.9	92.3	69.8425	58.9585
2025	4	11	20	33	9	12	0.3	3	0.89	90.4	69.8425	58.5282
2025	4	11	20	43	9	12	0.3	3	0.9	91	69.9081	58.801
2025	4	11	20	53	9	12	0.3	3	0.92	90.6	69.9081	60.5241
2025	4	11	21	3	9	12	0.3	3.3	0.91	91.7	69.9738	59.5054
2025	4	11	21	13	9	12	0.3	3.3	0.89	90	69.9738	58.4274
2025	4	11	21	23	9	12	0.3	3.3	0.96	91.6	69.9738	62.9551
2025	4	11	21	33	9	12	0.3	3.3	0.91	90.6	69.9738	59.5055
2025	4	11	21	43	9	12	0.3	3.3	0.89	94.2	69.9738	58.6432
2025	4	11	21	53	9	12	0.3	3.3	0.92	92.3	69.9738	60.1524
2025	4	11	22	3	9	12	0.3	3.3	0.91	90	69.9738	59.5057
2025	4	11	22	13	9	12	0.3	3.3	0.94	91.8	69.9738	61.4461
2025	4	11	22	23	9	12	0.3	3.3	0.91	90	69.9738	59.7214
2025	4	11	22	33	9	12	0.3	3.3	0.94	90.8	69.9738	62.093
2025	4	11	22	43	9	12	0.3	3.3	0.93	90.6	69.9738	60.7995
2025	4	11	22	53	9	12	0.3	3.3	0.95	92.6	69.9738	62.0931
2025	4	11	23	3	9	12	0.3	3.3	0.93	92.8	69.9738	61.2308
2025	4	11	23	13	9	12	0.3	3.3	0.93	90.2	69.9738	61.2308
2025	4	11	23	23	9	12	0.3	3.3	0.87	90.2	69.9738	57.1344
2025	4	11	23	33	9	12	0.3	3.3	0.92	91.8	69.9738	60.1529
2025	4	11	23	43	9	12	0.3	3.3	0.93	92	69.9738	61.0154
2025	4	11	23	53	9	12	0.3	3.3	0.89	93	69.9738	58.4282

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	12	0	3	9	12	0.3	3.3	0.91	93.1	69.9738	59.5062
2025	4	12	0	13	9	12	0.3	3.3	0.9	93.6	69.9738	58.8595
2025	4	12	0	23	9	12	0.3	3.3	0.91	88.3	69.9738	59.722
2025	4	12	0	33	9	12	0.3	3.3	0.9	92.9	69.9738	59.0752
2025	4	12	0	43	9	12	0.3	3.3	0.95	93.4	69.9738	62.3093
2025	4	12	0	53	9	12	0.3	3.3	0.93	91.2	69.9738	60.8001
2025	4	12	1	3	9	12	0.3	3.3	0.91	91.4	69.9738	59.9378
2025	4	12	1	13	9	12	0.3	3.3	0.92	92.5	69.9738	60.1534
2025	4	12	1	23	9	12	0.3	3.3	0.9	90	69.9738	58.8598
2025	4	12	1	33	9	12	0.3	3.3	0.91	91.5	69.9738	59.5067
2025	4	12	1	43	9	12	0.3	3.3	0.91	93.7	69.9738	59.5067
2025	4	12	1	53	9	12	0.3	3.3	0.95	92.6	69.9738	62.5252
2025	4	12	2	3	9	12	0.3	3.3	0.93	93.2	69.9738	61.0161
2025	4	12	2	13	9	12	0.3	3.3	0.93	91.8	69.9738	61.2317
2025	4	12	2	23	9	12	0.3	3.3	0.91	90	69.9738	59.5069
2025	4	12	2	33	9	12	0.3	3.3	0.91	93.5	69.9081	59.6642
2025	4	12	2	43	9	11.8	0.3	3.3	0.89	91.1	69.9081	58.1565
2025	4	12	2	53	9	11.8	0.3	3.3	0.94	93.8	69.9738	61.4475
2025	4	12	3	3	9	11.8	0.3	3.3	0.94	94.8	69.9081	61.6028
2025	4	12	3	13	9	11.8	0.3	3.3	0.91	90.6	69.9081	59.8797
2025	4	12	3	23	9	11.8	0.3	3.3	0.91	91.6	69.9081	59.8798
2025	4	12	3	33	9	11.8	0.3	3.3	0.89	91.9	69.9081	58.372
2025	4	12	3	43	9	11.8	0.3	3.3	0.91	92.9	69.9081	59.8798
2025	4	12	3	53	9	11.8	0.3	3.3	0.89	91.9	69.9081	58.1567
2025	4	12	4	3	9	11.8	0.3	3.3	0.9	91	69.9081	59.0183
2025	4	12	4	13	9	11.8	0.3	3.3	0.94	91.4	69.9081	61.3877
2025	4	12	4	23	9	11.8	0.3	3.3	0.9	91.7	69.9081	59.0184
2025	4	12	4	33	9	11.8	0.3	3.3	0.91	92.7	69.9081	59.88
2025	4	12	4	43	9	11.8	0.3	3.3	0.9	93.8	69.9081	59.0185
2025	4	12	4	53	9	11.8	0.3	3.3	0.96	91.6	69.9081	62.6803
2025	4	12	5	3	9	11.8	0.3	3.3	0.95	92.8	69.9081	62.2495
2025	4	12	5	13	9	11.8	0.3	3.3	0.95	92.4	69.9081	62.4649
2025	4	12	5	23	9	11.8	0.3	3.3	0.94	90.2	69.9081	61.6034
2025	4	12	5	33	9	11.8	0.3	3.3	0.91	93.5	69.9081	59.6648
2025	4	12	5	43	9	11.8	0.3	3.3	0.93	92.2	69.9081	60.7419
2025	4	12	5	53	9	11.8	0.3	3.3	0.9	91.7	69.9081	59.0187
2025	4	12	6	3	9	11.8	0.3	3.3	0.91	91	69.9081	59.8804
2025	4	12	6	13	9	11.8	0.3	3.3	0.91	91.7	69.8425	59.6066
2025	4	12	6	23	9	12.2	0.3	3.3	0.91	89.4	69.9081	59.665
2025	4	12	6	33	9	12.4	0.3	3.3	0.92	91.8	69.9081	60.5266
2025	4	12	6	43	9	12.6	0.3	3.3	0.93	92.4	69.9081	60.9575
2025	4	12	6	53	9	12.8	0.3	3.3	0.93	92	69.9081	60.9575
2025	4	12	7	3	9	12.8	0.3	3.3	0.92	89.4	69.8425	60.4675
2025	4	12	7	13	9	13	0.3	3.3	0.92	92	69.9081	60.5267
2025	4	12	7	23	9	13	0.3	3.3	0.91	91.2	69.9081	59.6651
2025	4	12	7	33	9	13	0.3	3.3	0.91	92.1	69.9081	59.8805
2025	4	12	7	43	9	13	0.3	3.3	0.93	91.2	69.9081	60.7421
2025	4	12	7	53	9	13	0.3	3.3	0.91	92.1	69.9081	59.8805

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	12	8	3	9	13	0.3	3.3	0.95	94	69.9081	62.0344
2025	4	12	8	13	9	13.2	0.3	3.3	0.96	91.4	69.9081	62.6806
2025	4	12	8	23	9	13.2	0.3	3.3	0.91	92.1	69.9081	59.8804
2025	4	12	8	33	9	13.2	0.3	3.3	0.94	92.8	69.9081	61.6035
2025	4	12	8	43	9	13.2	0.3	3.3	0.94	92.6	69.9081	61.8188
2025	4	12	8	53	9	13.2	0.3	3.3	0.93	90.4	69.9081	60.7418
2025	4	12	9	3	9	13.2	0.3	3.3	0.91	91.4	69.9081	59.8801
2025	4	12	9	13	9	13.2	0.3	3.3	0.95	92	69.9081	62.0341
2025	4	12	9	23	9	13.2	0.3	3.3	0.93	92	69.9081	60.7416
2025	4	12	9	33	9	13.2	0.3	3.3	0.93	92.6	69.9081	61.1723
2025	4	12	9	43	9	13.2	0.3	3.3	0.95	92.6	69.9081	62.0338
2025	4	12	9	53	9	13.2	0.3	3.3	0.95	92.2	69.9081	62.0338
2025	4	12	10	3	9	13.2	0.3	3.3	0.95	93.8	69.9081	62.2491
2025	4	12	10	13	9	13.2	0.3	3.3	0.95	93.2	69.9081	62.249
2025	4	12	10	23	9	13.2	0.3	3.3	0.91	91.4	69.9738	59.7226
2025	4	12	10	33	9	13.2	0.3	3.3	0.92	92.1	69.9738	60.1537
2025	4	12	10	43	9	13.2	0.3	3.3	0.92	92.9	69.9738	60.5848
2025	4	12	10	53	9	13.2	0.3	3.3	0.92	92.9	69.9738	60.5847
2025	4	12	11	3	9	13.2	0.3	3.3	0.9	91.2	69.9738	59.291
2025	4	12	11	13	9	13.2	0.3	3.3	0.93	90.6	70.0394	61.0754
2025	4	12	11	23	9	13.2	0.3	3.3	0.9	91.9	70.0394	59.3488
2025	4	12	11	33	9	13.2	0.3	3.3	0.96	91.8	69.9738	62.7404
2025	4	12	11	43	9	13.2	0.3	3.3	0.95	91.4	69.9738	62.3091
2025	4	12	11	53	9	13.2	0.3	3	0.91	91	69.9081	59.8788
2025	4	12	12	3	9	13.2	0.3	3.3	0.9	90.4	70.0394	59.3484
2025	4	12	12	13	9	13.2	0.3	3.3	0.91	93.7	70.0394	59.5642
2025	4	12	12	23	9	13.2	0.3	3.3	0.97	91.7	70.0394	63.8803
2025	4	12	12	33	9	13.2	0.3	3.3	0.9	92.9	70.0394	59.3482
2025	4	12	12	43	9	13.2	0.3	3.3	0.91	92.9	70.0394	59.7797
2025	4	12	12	53	9	13.2	0.3	3.3	0.9	91	70.0394	59.348
2025	4	12	13	3	9	13.2	0.3	3.3	0.96	92.5	70.105	63.0782
2025	4	12	13	13	9	13.4	0.3	3.3	0.89	93.6	70.0394	58.7004
2025	4	12	13	23	9	13.4	0.3	3.3	0.93	91.2	70.105	61.3499
2025	4	12	13	33	9	13.4	0.3	3.3	0.9	92.9	70.0394	58.9161
2025	4	12	13	43	9	13.4	0.3	3.3	0.93	91	70.1706	60.9771
2025	4	12	13	53	9	13.2	0.3	3.3	0.93	91.6	70.105	61.3497
2025	4	12	14	3	9	13.2	0.3	3.3	0.97	91.7	70.105	63.9418
2025	4	12	14	13	9	13.2	0.3	3.3	0.96	93.1	70.0394	62.8003
2025	4	12	14	23	9	13	0.3	3.3	0.94	92.8	70.0394	61.7212
2025	4	12	14	33	9	13	0.3	3.3	0.93	91.8	70.105	61.3494
2025	4	12	14	43	9	13.2	0.3	3.3	0.92	91.4	70.105	60.2693
2025	4	12	14	53	9	13.2	0.3	3.3	0.95	91	70.105	62.6454
2025	4	12	15	3	9	13.2	0.3	3.3	0.94	92	70.1706	61.8416
2025	4	12	15	13	9	13.2	0.3	3.3	0.96	92	70.1706	63.1389
2025	4	12	15	23	9	13.2	0.3	3.3	0.93	93	70.1706	61.4091
2025	4	12	15	33	9	13.2	0.3	3.3	0.94	91.2	70.1706	61.8415
2025	4	12	15	43	9	13.2	0.3	3.3	0.93	90	70.1706	61.409
2025	4	12	15	53	9	13.2	0.3	3.3	0.91	92.1	70.1706	60.1116

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	12	16	3	9	13.2	0.3	3.3	0.91	91	70.1706	59.8954
2025	4	12	16	13	9	13.2	0.3	3.3	0.93	91.6	70.1706	61.1928
2025	4	12	16	23	9	13.2	0.3	3.3	0.93	90	70.1706	61.409
2025	4	12	16	33	9	13.2	0.3	3.3	0.93	90.6	70.1706	60.9766
2025	4	12	16	43	9	13.2	0.3	3.3	0.91	90.4	70.1706	59.8954
2025	4	12	16	53	9	13.2	0.3	3.3	0.92	91.2	70.1706	60.5441
2025	4	12	17	3	9	12.6	0.3	3.3	0.89	89.2	70.1706	58.8143
2025	4	12	17	13	9	12.4	0.3	3.3	0.92	92.7	70.1706	60.5442
2025	4	12	17	23	9	12.4	0.3	3.3	0.9	91	70.1706	59.0306
2025	4	12	17	33	9	12.2	0.3	3.3	0.92	92.5	70.1706	60.328
2025	4	12	17	43	9	12.2	0.3	3.3	0.92	91.2	70.1706	60.7605
2025	4	12	17	53	9	12.2	0.3	3.3	0.92	90.8	70.1706	60.3281
2025	4	12	18	3	9	12.2	0.3	3.3	0.94	89.8	70.1706	61.8418
2025	4	12	18	13	9	12.2	0.3	3.3	0.94	89.4	70.2362	61.6857
2025	4	12	18	23	9	12.2	0.3	3.3	0.94	89.6	70.2362	61.6857
2025	4	12	18	33	9	12.2	0.3	3.3	0.9	90.4	70.2362	59.3049
2025	4	12	18	43	9	12.2	0.3	3.3	0.93	91.4	70.2362	61.4694
2025	4	12	18	53	9	12.2	0.3	3.3	0.92	92.6	70.2362	60.8201
2025	4	12	19	3	9	12.2	0.3	3.3	0.94	90.6	70.2362	62.3353
2025	4	12	19	13	9	12.2	0.3	3.3	0.93	90.2	70.2362	61.4695
2025	4	12	19	23	9	12.2	0.3	3.3	0.93	91.2	70.2362	61.4696
2025	4	12	19	33	9	12.2	0.3	3.3	0.93	91	70.2362	61.0367
2025	4	12	19	43	9	12.2	0.3	3.3	0.93	91.2	70.2362	61.4697
2025	4	12	19	53	9	12.2	0.3	3.3	0.95	90	70.2362	62.9848
2025	4	12	20	3	9	12	0.3	3.3	0.93	91.8	70.2362	61.2533
2025	4	12	20	13	9	12	0.3	3.3	0.96	92.6	70.2362	62.9849
2025	4	12	20	23	9	12	0.3	3.3	0.9	91.9	70.2362	59.3054
2025	4	12	20	33	9	12	0.3	3.3	0.92	92.2	70.2362	60.8206
2025	4	12	20	43	9	12	0.3	3.3	0.93	91.8	70.2362	61.0371
2025	4	12	20	53	9	12	0.3	3.3	0.96	91.8	70.2362	63.2016
2025	4	12	21	3	9	12	0.3	3.3	0.94	90.8	70.2362	61.903
2025	4	12	21	13	9	12	0.3	3.3	0.94	91.8	70.2362	61.903
2025	4	12	21	23	9	12	0.3	3.3	0.95	91.8	70.2362	62.3359
2025	4	12	21	33	9	12	0.3	3.3	0.91	90	70.2362	60.1715
2025	4	12	21	43	9	12	0.3	3.3	0.95	93.4	70.2362	62.336
2025	4	12	21	53	9	12	0.3	3.3	0.94	90.8	70.1706	61.8429
2025	4	12	22	3	9	12	0.3	3.3	0.95	91.6	70.1706	62.4917
2025	4	12	22	13	9	12	0.3	3.3	0.93	92	70.1706	61.1943
2025	4	12	22	23	9	12	0.3	3.3	0.94	93.6	70.2362	62.1198
2025	4	12	22	33	9	12	0.3	3.3	0.94	90.8	70.1706	61.6269
2025	4	12	22	43	9	12	0.3	3.3	0.93	91.6	70.1706	61.1945
2025	4	12	22	53	9	12	0.3	3.3	0.94	90.2	70.1706	62.0595
2025	4	12	23	3	9	12	0.3	3.3	0.93	92.2	70.1706	61.1946
2025	4	12	23	13	9	12	0.3	3.3	0.93	90.4	70.1706	61.4109
2025	4	12	23	23	9	12	0.3	3.3	0.93	94.6	70.1706	61.1947
2025	4	12	23	33	9	12	0.3	3.3	0.92	91	70.1706	60.3298
2025	4	12	23	43	9	12	0.3	3.3	0.93	92.8	70.1706	61.411
2025	4	12	23	53	9	12	0.3	3.3	0.92	92	70.1706	60.7624

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	13	0	3	9	12	0.3	3.3	0.94	91.6	70.1706	62.0599
2025	4	13	0	13	9	12	0.3	3.3	0.92	90.2	70.1706	60.5463
2025	4	13	0	23	9	12	0.3	3.3	0.93	91	70.1706	60.9788
2025	4	13	0	33	9	12	0.3	3.3	0.95	92.2	70.1706	62.2763
2025	4	13	0	43	9	12	0.3	3.3	0.93	94.7	70.1706	60.9789
2025	4	13	0	53	9	12	0.3	3.3	0.97	92.1	70.2362	64.0687
2025	4	13	1	3	9	12	0.3	3.3	0.97	92.1	70.2362	64.0687
2025	4	13	1	13	9	12	0.3	3.3	0.94	91	70.1706	62.0603
2025	4	13	1	23	9	12	0.3	3.3	0.89	90.8	70.2362	58.8741
2025	4	13	1	33	9	12	0.3	3.3	0.93	91.8	70.2362	61.4715
2025	4	13	1	43	9	12	0.3	3.3	0.92	91	70.2362	60.6058
2025	4	13	1	53	9	12	0.3	3.3	0.93	94.2	70.2362	61.4716
2025	4	13	2	3	9	12	0.3	3.3	0.98	91.3	70.2362	64.9348
2025	4	13	2	13	9	12	0.3	3.3	0.92	91.8	70.3018	60.6649
2025	4	13	2	23	9	12	0.3	3.3	0.94	92.2	70.2362	61.9046
2025	4	13	2	33	9	12	0.3	3.3	0.96	93.1	70.3018	63.0483
2025	4	13	2	43	9	12	0.3	3.3	0.93	92.8	70.2362	61.0389
2025	4	13	2	53	9	12	0.3	3.3	0.92	93.5	70.2362	60.6061
2025	4	13	3	3	9	12	0.3	3.3	0.93	92.6	70.2362	61.4719
2025	4	13	3	13	9	12	0.3	3.3	0.96	91.8	70.2362	62.9871
2025	4	13	3	23	9	12	0.3	3.3	0.93	90.8	70.3018	61.3152
2025	4	13	3	33	9	12	0.3	3.3	0.95	92	70.3018	62.3986
2025	4	13	3	43	9	12	0.3	3.3	0.94	94.8	70.3018	62.1819
2025	4	13	3	53	9	12	0.3	3.3	0.92	91.8	70.3018	60.882
2025	4	13	4	3	9	11.8	0.3	3.3	0.95	92.2	70.2362	62.7709
2025	4	13	4	13	9	11.8	0.3	3.3	0.95	92	70.3018	62.3988
2025	4	13	4	23	9	11.8	0.3	3.3	0.92	93.1	70.3018	60.6655
2025	4	13	4	33	9	11.8	0.3	3.3	0.95	94.1	70.2362	62.771
2025	4	13	4	43	9	11.8	0.3	3.3	0.93	93	70.3018	61.5322
2025	4	13	4	53	9	11.8	0.3	3.3	0.94	91.4	70.3018	61.749
2025	4	13	5	3	9	11.8	0.3	3.3	0.93	92.4	70.2362	61.256
2025	4	13	5	13	9	11.8	0.3	3.3	0.94	90.8	70.3018	61.749
2025	4	13	5	23	9	11.8	0.3	3.3	0.93	93	70.3018	61.3158
2025	4	13	5	33	9	11.8	0.3	3.3	0.91	91.4	70.3018	60.2325
2025	4	13	5	43	9	11.8	0.3	3.3	0.93	93.4	70.3018	61.5325
2025	4	13	5	53	9	11.8	0.3	3.3	0.9	90.6	70.3018	59.3659
2025	4	13	6	3	9	11.8	0.3	3.3	0.96	92.2	70.3018	63.4826
2025	4	13	6	13	9	12	0.3	3.3	0.94	93	70.3018	62.1826
2025	4	13	6	23	9	12.2	0.3	3.3	0.93	94.4	70.3018	61.5327
2025	4	13	6	33	9	12.4	0.3	3.3	0.91	93.3	70.3018	60.2327
2025	4	13	6	43	9	12.6	0.3	3.3	0.93	91.2	70.2362	61.2565
2025	4	13	6	53	9	12.6	0.3	3.3	0.94	92.8	70.2362	61.9058
2025	4	13	7	3	9	12.8	0.3	3.3	0.96	92	70.2362	63.2046
2025	4	13	7	13	9	12.8	0.3	3.3	0.97	91.4	70.1706	63.7918
2025	4	13	7	23	9	12.8	0.3	3.3	0.95	93.7	70.2362	62.7717
2025	4	13	7	33	9	12.8	0.3	3.3	0.94	91.4	70.2362	62.1224
2025	4	13	7	43	9	12.8	0.3	3.3	0.93	90	70.2362	61.0401
2025	4	13	7	53	9	13	0.3	3.3	0.97	92.1	70.2362	64.0705

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	13	8	3	9	13	0.3	3.3	0.92	92.5	70.1706	60.3319
2025	4	13	8	13	9	13	0.3	3.3	0.94	91.2	70.2362	61.6894
2025	4	13	8	23	9	13	0.3	3.3	0.91	90.4	70.2362	60.1742
2025	4	13	8	33	9	13.2	0.3	3.3	0.95	93.6	70.1706	62.2781
2025	4	13	8	43	9	13.6	0.3	3.3	0.93	93.2	70.2362	61.04
2025	4	13	8	53	9	13.6	0.3	3.3	0.93	91.8	70.2362	61.04
2025	4	13	9	3	9	13.6	0.3	3.3	0.91	92.7	70.1706	60.1155
2025	4	13	9	13	9	13.8	0.3	3.3	0.94	92.6	70.2362	61.9057
2025	4	13	9	23	9	13.6	0.3	3.3	0.91	91.9	70.2362	59.7411
2025	4	13	9	33	9	13.6	0.3	3.3	0.94	92	70.2362	62.1221
2025	4	13	9	43	9	13.8	0.3	3.3	0.92	94.3	70.2362	60.6068
2025	4	13	9	53	9	13.8	0.3	3.3	0.94	90.4	70.2362	62.3384
2025	4	13	10	3	9	13.6	0.3	3.3	0.95	93.6	70.2362	62.3383
2025	4	13	10	13	9	13.6	0.3	3.3	0.9	91	70.2362	59.0915
2025	4	13	10	23	9	13.6	0.3	3.3	0.93	90.8	70.2362	61.4724
2025	4	13	10	33	9	13.6	0.3	3.3	0.94	91.4	70.2362	61.6888
2025	4	13	10	43	9	13.6	0.3	3.3	0.92	92.9	70.1706	60.5474
2025	4	13	10	53	9	13.6	0.3	3.3	0.93	92	70.2362	61.2557
2025	4	13	11	3	9	13.6	0.3	3.3	0.91	90.6	70.2362	59.9569
2025	4	13	11	13	9	13.6	0.3	3.3	0.94	93.2	70.1706	62.0608
2025	4	13	11	23	9	13.6	0.3	3.3	0.91	91.9	70.2362	59.7403
2025	4	13	11	33	9	13.6	0.3	3.3	0.96	92.6	70.1706	62.9256
2025	4	13	11	43	9	13.6	0.3	3.3	0.91	91.7	70.1706	59.6819
2025	4	13	11	53	9	13.6	0.3	3.3	0.92	89.6	70.1706	60.5468
2025	4	13	12	3	9	13.6	0.3	3.3	0.91	90.2	70.1706	59.6817
2025	4	13	12	13	9	13.6	0.3	3.3	0.92	91	70.105	60.2716
2025	4	13	12	23	9	13.6	0.3	3.3	0.92	92.7	70.1706	60.5465
2025	4	13	12	33	9	13.6	0.3	3.3	0.94	92.4	70.105	61.9996
2025	4	13	12	43	9	13.6	0.3	3.3	0.91	90.6	70.1706	60.1139
2025	4	13	12	53	9	13.6	0.3	3.3	0.93	92.6	70.1706	61.195
2025	4	13	13	3	9	13.4	0.3	3.3	0.92	91.8	70.1706	60.5462
2025	4	13	13	13	9	13.4	0.3	3.3	0.94	91.4	70.1706	61.8435
2025	4	13	13	23	9	13.2	0.3	3.3	0.94	89.8	70.1706	62.0596
2025	4	13	13	33	9	13.4	0.3	3.3	0.93	93	70.1706	61.1946
2025	4	13	13	43	9	13.4	0.3	3.3	0.93	92.8	70.1706	61.4107
2025	4	13	13	53	9	13.4	0.3	3.3	0.94	91.8	70.1706	61.8431
2025	4	13	14	3	9	13.4	0.3	3.3	0.92	91	70.1706	60.7619
2025	4	13	14	13	9	13.4	0.3	3.3	0.94	92.6	70.1706	61.6267
2025	4	13	14	23	9	13.4	0.3	3.3	0.93	92	70.1706	61.4104
2025	4	13	14	33	9	13.4	0.3	3.3	0.93	90.2	70.1706	61.4104
2025	4	13	14	43	9	13.4	0.3	3.3	0.95	90	70.2362	62.9853
2025	4	13	14	53	9	13.4	0.3	3.3	0.95	92.4	70.2362	62.3359
2025	4	13	15	3	9	13.4	0.3	3.3	0.94	92	70.2362	61.9029
2025	4	13	15	13	9	13.4	0.3	3.3	0.91	92.7	70.2362	59.9549
2025	4	13	15	23	9	13.4	0.3	3.3	0.95	93.6	70.2362	62.5522
2025	4	13	15	33	9	13.4	0.3	3.3	0.91	91.9	70.2362	60.1712
2025	4	13	15	43	9	13.4	0.3	3.3	0.91	90	70.2362	60.1712
2025	4	13	15	53	9	13.4	0.3	3.3	0.94	92.2	70.2362	61.9028

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	13	16	3	9	13	0.3	3.3	0.96	92.6	70.2362	62.985
2025	4	13	16	13	9	13.2	0.3	3.3	0.92	90.8	70.2362	60.6041
2025	4	13	16	23	9	13.2	0.3	3.3	0.96	91.8	70.2362	63.2014
2025	4	13	16	33	9	13.2	0.3	3.3	0.94	90.2	70.2362	62.1192
2025	4	13	16	43	9	13.2	0.3	3.3	0.94	90.6	70.2362	62.1192
2025	4	13	16	53	9	12.6	0.3	3.3	0.93	91.8	70.2362	61.2534
2025	4	13	17	3	9	12.4	0.3	3.3	0.93	89.4	70.2362	61.037
2025	4	13	17	13	9	12.4	0.3	3.3	0.94	92.6	70.2362	62.1192
2025	4	13	17	23	9	12.4	0.3	3.3	0.97	93.5	70.2362	63.6343
2025	4	13	17	33	9	12.2	0.3	3.3	0.92	91.8	70.2362	60.6041
2025	4	13	17	43	9	12.2	0.3	3.3	0.94	90.4	70.2362	62.3357
2025	4	13	17	53	9	12.2	0.3	3.3	0.94	90.8	70.2362	61.6864
2025	4	13	18	3	9	12.2	0.3	3.3	0.98	91.1	70.2362	64.7166
2025	4	13	18	13	9	12.2	0.3	3.3	0.94	92.6	70.2362	61.9029
2025	4	13	18	23	9	12.2	0.3	3.3	0.95	92	70.2362	62.7687
2025	4	13	18	33	9	12.2	0.3	3.3	0.91	92.9	70.2362	60.1714
2025	4	13	18	43	9	12.2	0.3	3.3	0.95	91.6	70.2362	62.5523
2025	4	13	18	53	9	12.2	0.3	3.3	0.95	93.6	70.1706	62.4914
2025	4	13	19	3	9	12.2	0.3	3.3	0.93	90.8	70.1706	61.4103
2025	4	13	19	13	9	12.2	0.3	3.3	0.94	91.6	70.1706	61.6266
2025	4	13	19	23	9	12.2	0.3	3.3	0.95	91.8	70.1706	62.2753
2025	4	13	19	33	9	12.2	0.3	3.3	0.92	93.1	70.1706	60.5455
2025	4	13	19	43	9	12.2	0.3	3.3	0.92	91	70.1706	60.5455
2025	4	13	19	53	9	12.2	0.3	3.3	0.95	92.6	70.1706	62.4917
2025	4	13	20	3	9	12	0.3	3.3	0.93	92.8	70.1706	61.4105
2025	4	13	20	13	9	12	0.3	3.3	0.94	90.2	70.1706	62.0593
2025	4	13	20	23	9	12	0.3	3.3	0.93	92	70.1706	61.1944
2025	4	13	20	33	9	12	0.3	3.3	0.93	92.8	70.105	61.3508
2025	4	13	20	43	9	12	0.3	3.3	0.9	93.8	70.105	58.9746
2025	4	13	20	53	9	12	0.3	3.3	0.95	90	70.105	62.431
2025	4	13	21	3	9	12	0.3	3.3	0.95	92.4	70.105	62.4311
2025	4	13	21	13	9	12	0.3	3.3	0.95	91	70.105	62.4311
2025	4	13	21	23	9	12	0.3	3.3	0.93	91.2	70.105	61.1351
2025	4	13	21	33	9	12	0.3	3.3	0.92	94.7	70.105	60.271
2025	4	13	21	43	9	12	0.3	3.3	0.94	91.8	70.105	61.9993
2025	4	13	21	53	9	12	0.3	3.3	0.93	91.6	70.0394	60.8597
2025	4	13	22	3	9	12	0.3	3.3	0.93	93.2	70.0394	61.0756
2025	4	13	22	13	9	12	0.3	3.3	0.94	91.4	70.0394	61.7231
2025	4	13	22	23	9	12	0.3	3.3	0.92	92.1	70.0394	60.2125
2025	4	13	22	33	9	12	0.3	3.3	0.9	90	70.0394	58.9176
2025	4	13	22	43	9	12	0.3	3.3	0.95	90.4	69.9738	62.3098
2025	4	13	22	53	9	12	0.3	3.3	0.91	90.6	69.9738	59.507
2025	4	13	23	3	9	12	0.3	3.3	0.94	92.6	69.9738	61.4475
2025	4	13	23	13	9	12	0.3	3.3	0.91	93.3	69.9738	59.9383
2025	4	13	23	23	9	12	0.3	3.3	0.93	92.6	69.9738	61.232
2025	4	13	23	33	9	12	0.3	3.3	0.92	91.8	69.9738	60.3697
2025	4	13	23	43	9	12	0.3	3.3	0.94	92.2	69.9081	61.6031
2025	4	13	23	53	9	12	0.3	3.3	0.91	92.5	69.9081	59.6646

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	14	0	3	9	12	0.3	3.3	0.95	91.8	69.9081	62.2494
2025	4	14	0	13	9	12	0.3	3.3	0.92	94.9	69.9081	59.88
2025	4	14	0	23	9	12	0.3	3.3	0.92	93.3	69.9081	60.5263
2025	4	14	0	33	9	12	0.3	3.3	0.95	91.8	69.8425	61.9734
2025	4	14	0	43	9	12	0.3	3.3	0.9	91	69.8425	59.176
2025	4	14	0	53	9	12	0.3	3.3	0.93	91.2	69.8425	61.1127
2025	4	14	1	3	9	12	0.3	3.3	0.93	90	69.8425	60.6824
2025	4	14	1	13	9	12	0.3	3.3	0.91	90.8	69.8425	59.6065
2025	4	14	1	23	9	12	0.3	3.3	0.94	91.6	69.8425	61.5432
2025	4	14	1	33	9	12	0.3	3.3	0.92	91.6	69.8425	60.037
2025	4	14	1	43	9	12	0.3	3.3	0.91	94.1	69.7769	59.7632
2025	4	14	1	53	9	12	0.3	3.3	0.94	91.6	69.7769	61.698
2025	4	14	2	3	9	12	0.3	3.3	0.88	92.3	69.7769	57.8285
2025	4	14	2	13	9	12	0.3	3.3	0.9	92.7	69.7769	58.9034
2025	4	14	2	23	9	12	0.3	3.3	0.94	90.8	69.7769	61.2682
2025	4	14	2	33	9	12	0.3	3.3	0.93	92.6	69.7769	60.6233
2025	4	14	2	43	9	12	0.3	3.3	0.91	91.7	69.7113	59.2753
2025	4	14	2	53	9	12	0.3	3.3	0.88	91.1	69.7113	57.3425
2025	4	14	3	3	9	12	0.3	3.3	0.93	90.6	69.7113	60.9935
2025	4	14	3	13	9	12	0.3	3.3	0.93	91.2	69.7113	60.9936
2025	4	14	3	23	9	12	0.3	3.3	0.93	90.8	69.7113	60.7788
2025	4	14	3	33	9	11.8	0.3	3.3	0.88	92.1	69.7113	57.5574
2025	4	14	3	43	9	11.8	0.3	3.3	0.94	91.2	69.7113	61.2084
2025	4	14	3	53	9	11.8	0.3	3.3	0.97	92.9	69.6457	63.0794
2025	4	14	4	3	9	11.8	0.3	3.3	0.89	93.6	69.6457	58.1447
2025	4	14	4	13	9	11.8	0.3	3.3	0.9	92.5	69.6457	58.7884
2025	4	14	4	23	9	11.8	0.3	3.3	0.92	90.8	69.6457	60.2903
2025	4	14	4	33	9	11.8	0.3	3.3	0.9	92.7	69.6457	58.7885
2025	4	14	4	43	9	11.8	0.3	3.3	0.9	91.5	69.6457	58.7885
2025	4	14	4	53	9	11.8	0.3	3.3	0.92	92.7	69.6457	60.0759
2025	4	14	5	3	9	11.8	0.3	3.3	0.9	91.9	69.6457	58.7886
2025	4	14	5	13	9	11.8	0.3	3.3	0.94	94.4	69.5801	61.5174
2025	4	14	5	23	9	11.8	0.3	3.3	0.9	92.1	69.5801	58.7309
2025	4	14	5	33	9	11.8	0.3	3.3	0.91	93.3	69.6457	59.4324
2025	4	14	5	43	9	11.8	0.3	3.3	0.91	93.5	69.5801	59.374
2025	4	14	5	53	9	11.8	0.3	3.3	0.92	94.1	69.5801	59.8027
2025	4	14	6	3	9	11.8	0.3	3.3	0.9	93.3	69.5801	58.9454
2025	4	14	6	13	9	12	0.3	3.3	0.93	93	69.5801	60.4458
2025	4	14	6	23	9	12.2	0.3	3.3	0.89	92.1	69.5801	58.088
2025	4	14	6	33	9	12.4	0.3	3.3	0.94	91.6	69.5801	61.3032
2025	4	14	6	43	9	12.6	0.3	3.3	0.87	92.2	69.5801	56.5876
2025	4	14	6	53	9	12.6	0.3	3.3	0.91	93.5	69.5801	59.3741
2025	4	14	7	3	9	12.8	0.3	3.3	0.89	93.6	69.5801	58.088
2025	4	14	7	13	9	12.8	0.3	3.3	0.93	91.8	69.5144	60.3864
2025	4	14	7	23	9	12.8	0.3	3.3	0.89	93.4	69.5801	58.3024
2025	4	14	7	33	9	12.8	0.3	3.3	0.92	93.9	69.5801	60.0171
2025	4	14	7	43	9	12.8	0.3	3.3	0.92	90	69.5144	60.1722
2025	4	14	7	53	9	13	0.3	3.3	0.91	91.9	69.5801	59.5884

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	14	8	3	9	13	0.3	3.3	0.88	91.1	69.5144	57.6025
2025	4	14	8	13	9	13	0.3	3.3	0.91	94.8	69.5801	59.1596
2025	4	14	8	23	9	13.2	0.3	3.3	0.94	91.8	69.5801	61.303
2025	4	14	8	33	9	13.2	0.3	3.3	0.91	92.5	69.5144	59.1014
2025	4	14	8	43	9	13.2	0.3	3.3	0.92	92.9	69.5801	60.0169
2025	4	14	8	53	9	13.6	0.3	3.3	0.91	91.9	69.5144	59.1013
2025	4	14	9	3	9	13.4	0.3	3.3	0.92	91.4	69.5801	59.8024
2025	4	14	9	13	9	13.6	0.3	3.3	0.97	92.5	69.5801	63.0175
2025	4	14	9	23	9	13.6	0.3	3.3	0.94	92.8	69.5801	61.5171
2025	4	14	9	33	9	13.6	0.3	3.3	0.88	93	69.5801	57.2301
2025	4	14	9	43	9	13.6	0.3	3.3	0.86	90.4	69.5144	56.3172
2025	4	14	9	53	9	13.6	0.3	3.3	0.94	91.8	69.5801	61.3025
2025	4	14	10	3	9	13.6	0.3	3.3	0.91	92.5	69.5801	59.5877
2025	4	14	10	13	9	13.6	0.3	3.3	0.89	92.7	69.5801	58.0872
2025	4	14	10	23	9	13.6	0.3	3.3	0.9	93.8	69.5801	58.5158
2025	4	14	10	33	9	13.6	0.3	3.3	0.9	92.1	69.5801	58.5158
2025	4	14	10	43	9	13.6	0.3	3.3	0.89	91.1	69.5144	58.244
2025	4	14	10	53	9	13.6	0.3	3.3	0.92	92	69.5144	59.957
2025	4	14	11	3	9	13.6	0.3	3.3	0.94	93.6	69.5144	61.0276
2025	4	14	11	13	9	13.4	0.3	3.3	0.93	93	69.4488	60.3257
2025	4	14	11	23	9	13.4	0.3	3.3	0.92	90.4	69.4488	59.8978
2025	4	14	11	33	9	13.4	0.3	3.3	0.94	94.4	69.4488	61.3951
2025	4	14	11	43	9	13.4	0.3	3.3	0.95	91.4	69.3832	61.5483
2025	4	14	11	53	9	13.4	0.3	3.3	0.89	91.3	69.3832	57.7014
2025	4	14	12	3	9	13.4	0.3	3.3	0.9	94	69.3832	58.3425
2025	4	14	12	13	9	13.4	0.3	3.3	0.9	92.1	69.3832	58.5561
2025	4	14	12	23	9	13.4	0.3	3.3	0.93	94.6	69.3832	60.4795
2025	4	14	12	33	9	13.4	0.3	3.3	0.9	90.4	69.3832	58.556
2025	4	14	12	43	9	13.4	0.3	3.3	0.93	92.4	69.3832	60.2656
2025	4	14	12	53	9	13.4	0.3	3.3	0.93	92.8	69.3832	60.2655
2025	4	14	13	3	9	13.4	0.3	3.3	0.88	91.5	69.3832	57.2735
2025	4	14	13	13	9	13.4	0.3	3.3	0.94	90.8	69.3832	61.1202
2025	4	14	13	23	9	13.4	0.3	3.3	0.94	90.6	69.3832	61.5475
2025	4	14	13	33	9	13.4	0.3	3.3	0.92	92.7	69.4488	59.8968
2025	4	14	13	43	9	13.4	0.3	3.3	0.91	92.3	69.5801	59.3717
2025	4	14	13	53	9	13.4	0.3	3	0.91	91	69.4488	59.041
2025	4	14	14	3	9	13.4	0.3	3	0.91	91	69.4488	59.4687
2025	4	14	14	13	9	13.4	0.3	3	0.92	91	69.5144	59.7414
2025	4	14	14	23	9	13.4	0.3	3	0.92	89.8	69.4488	59.6825
2025	4	14	14	33	9	13.4	0.3	3	0.91	91	69.4488	59.2547
2025	4	14	14	43	9	13.2	0.3	3	0.9	90.2	69.4488	58.6128
2025	4	14	14	53	9	13	0.3	3	0.95	91	69.5144	61.6683
2025	4	14	15	3	9	13.2	0.3	3	0.94	91.4	69.5144	61.0259
2025	4	14	15	13	9	13.2	0.3	3	0.9	91	69.5144	58.4563
2025	4	14	15	23	9	13.2	0.3	3	0.9	92.9	69.5144	58.8845
2025	4	14	15	33	9	13.2	0.3	3	0.94	90.8	69.5144	61.2399
2025	4	14	15	43	9	13.2	0.3	3	0.96	93.1	69.5144	62.5246
2025	4	14	15	53	9	13	0.3	3	0.92	94.7	69.5144	60.1692

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	14	16	3	9	13	0.3	3	0.91	93.1	69.5144	59.5268
2025	4	14	16	13	9	13	0.3	3	0.93	93.2	69.5801	60.4427
2025	4	14	16	23	9	13	0.3	3	0.94	90.6	69.5801	61.5143
2025	4	14	16	33	9	13	0.3	3	0.94	91.8	69.5801	61.5143
2025	4	14	16	43	9	13	0.3	3	0.94	90.2	69.5801	61.5143
2025	4	14	16	53	9	13.2	0.3	3	0.93	91.8	69.5801	60.657
2025	4	14	17	3	9	12.6	0.3	3	0.89	90.8	69.5801	57.8706
2025	4	14	17	13	9	12.4	0.3	3	0.93	92.6	69.5801	60.4427
2025	4	14	17	23	9	12.4	0.3	3	0.9	91.7	69.5801	58.728
2025	4	14	17	33	9	12.2	0.3	3	0.91	91	69.5144	59.0985
2025	4	14	17	43	9	12.2	0.3	3	0.89	91.9	69.5801	58.2994
2025	4	14	17	53	9	12.2	0.3	3	0.91	92.7	69.5801	59.3711
2025	4	14	18	3	9	12.2	0.3	3	0.91	90	69.5801	59.5854
2025	4	14	18	13	9	12.2	0.3	3	0.94	90.6	69.5801	61.5145
2025	4	14	18	23	9	12.2	0.3	3	0.95	90.8	69.5801	62.1575
2025	4	14	18	33	9	12.2	0.3	3	0.88	93.6	69.5801	57.4421
2025	4	14	18	43	9	12.2	0.3	3	0.93	92.8	69.5801	60.8715
2025	4	14	18	53	9	12.2	0.3	3	0.89	91.1	69.5801	58.2995
2025	4	14	19	3	9	12.2	0.3	3	0.91	92.7	69.5801	59.3712
2025	4	14	19	13	9	12.2	0.3	3	0.88	91.1	69.5801	57.2279
2025	4	14	19	23	9	12.2	0.3	3	0.91	91.5	69.5801	59.157
2025	4	14	19	33	9	12.2	0.3	3	0.94	90.8	69.5801	61.086
2025	4	14	19	43	9	12.2	0.3	3	0.93	90	69.5801	60.8717
2025	4	14	19	53	9	12.2	0.3	3	0.95	92	69.5801	61.9435
2025	4	14	20	3	9	12	0.3	3	0.9	90.8	69.5801	58.9428
2025	4	14	20	13	9	12	0.3	3	0.95	91.8	69.5801	61.7292
2025	4	14	20	23	9	12	0.3	3	0.92	90.2	69.6457	59.859
2025	4	14	20	33	9	12	0.3	3	0.92	91.8	69.6457	59.8591
2025	4	14	20	43	9	12	0.3	3	0.9	92.7	69.6457	58.7864
2025	4	14	20	53	9	12	0.3	3	0.91	90.4	69.7113	59.2737
2025	4	14	21	3	9	12	0.3	3	0.93	92.4	69.7113	60.777
2025	4	14	21	13	9	12	0.3	3.3	0.89	91.5	69.7113	58.2
2025	4	14	21	23	9	12	0.3	3.3	0.91	93.3	69.7769	59.7619
2025	4	14	21	33	9	12	0.3	3.3	0.93	91	69.7113	60.9919
2025	4	14	21	43	9	12	0.3	3.3	0.95	91.8	69.7113	61.851
2025	4	14	21	53	9	12	0.3	3.3	0.93	91.8	69.7769	61.0519
2025	4	14	22	3	9	12	0.3	3.3	0.92	91	69.7113	59.9183
2025	4	14	22	13	9	12	0.3	3.3	0.9	91.9	69.7113	58.8445
2025	4	14	22	23	9	12	0.3	3.3	0.92	91.8	69.7113	60.1331
2025	4	14	22	33	9	12	0.3	3.3	0.91	91.9	69.7113	59.4889
2025	4	14	22	43	9	12	0.3	3.3	0.91	91.9	69.7769	59.7623
2025	4	14	22	53	9	12	0.3	3.3	0.93	92.8	69.7113	60.9923
2025	4	14	23	3	9	12	0.3	3.3	0.92	91.8	69.7769	60.1924
2025	4	14	23	13	9	12	0.3	3.3	0.93	88.4	69.7113	60.7777
2025	4	14	23	23	9	12	0.3	3.3	0.87	90.9	69.7769	56.7529
2025	4	14	23	33	9	12	0.3	3.3	0.93	90	69.7113	60.563
2025	4	14	23	43	9	12	0.3	3.3	0.89	90.6	69.7113	57.9859
2025	4	14	23	53	9	12	0.3	3.3	0.89	92.5	69.7113	58.4155

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	15	0	3	9	12	0.3	3.3	0.93	93.6	69.7113	60.9927
2025	4	15	0	13	9	12	0.3	3.3	0.96	92.5	69.7113	62.7109
2025	4	15	0	23	9	12	0.3	3.3	0.93	91.6	69.7113	60.7781
2025	4	15	0	33	9	12	0.3	3.3	0.92	90	69.7113	59.9191
2025	4	15	0	43	9	12	0.3	3.3	0.92	91.2	69.7113	60.3486
2025	4	15	0	53	9	12	0.3	3.3	0.9	92.3	69.7113	58.8453
2025	4	15	1	3	9	12	0.3	3.3	0.89	90.8	69.7113	58.4159
2025	4	15	1	13	9	12	0.3	3.3	0.91	92.7	69.7113	59.7045
2025	4	15	1	23	9	12	0.3	3.3	0.89	90	69.7113	57.9864
2025	4	15	1	33	9	12	0.3	3.3	0.92	92.4	69.7113	60.3489
2025	4	15	1	43	9	12	0.3	3.3	0.93	91.2	69.7113	60.9932
2025	4	15	1	53	9	12	0.3	3.3	0.93	90	69.7113	60.5638
2025	4	15	2	3	9	12	0.3	3.3	0.91	90.2	69.7113	59.49
2025	4	15	2	13	9	12	0.3	3.3	0.92	92.5	69.7113	60.1343
2025	4	15	2	23	9	11.8	0.3	3.3	0.88	92.8	69.7113	57.3424
2025	4	15	2	33	9	11.8	0.3	3.3	0.93	90.8	69.7113	60.5639
2025	4	15	2	43	9	11.8	0.3	3.3	0.91	90.4	69.7113	59.7049
2025	4	15	2	53	9	11.8	0.3	3.3	0.92	93.3	69.6457	59.8609
2025	4	15	3	3	9	11.8	0.3	3.3	0.91	92.3	69.7113	59.4902
2025	4	15	3	13	9	11.8	0.3	3.3	0.88	93	69.6457	57.7154
2025	4	15	3	23	9	11.8	0.3	3.3	0.95	91.6	69.6457	62.0065
2025	4	15	3	33	9	11.8	0.3	3.3	0.9	92.5	69.6457	58.5737
2025	4	15	3	43	9	11.8	0.3	3.3	0.94	90	69.6457	61.5775
2025	4	15	3	53	9	11.8	0.3	3.3	0.93	91.2	69.6457	60.5047
2025	4	15	4	3	9	11.8	0.3	3.3	0.91	92.5	69.6457	59.6465
2025	4	15	4	13	9	11.8	0.3	3.3	0.95	92	69.6457	62.0067
2025	4	15	4	23	9	11.8	0.3	3.3	0.95	90.2	69.6457	62.2213
2025	4	15	4	33	9	11.8	0.3	3.3	0.93	93.6	69.6457	60.7194
2025	4	15	4	43	9	11.8	0.3	3.3	0.93	91.8	69.6457	60.7195
2025	4	15	4	53	9	11.8	0.3	3.3	0.9	92.7	69.6457	58.7885
2025	4	15	5	3	9	11.8	0.3	3.3	0.93	95.1	69.6457	60.2904
2025	4	15	5	13	9	11.8	0.3	3.3	0.92	93.3	69.6457	60.0759
2025	4	15	5	23	9	11.8	0.3	3.3	0.97	93.3	69.6457	63.2943
2025	4	15	5	33	9	11.8	0.3	3.3	0.89	91.9	69.6457	58.3595
2025	4	15	5	43	9	11.8	0.3	3.3	0.98	92.1	69.5801	63.8752
2025	4	15	5	53	9	11.8	0.3	3.3	0.94	94	69.6457	61.5779
2025	4	15	6	3	9	11.8	0.3	3.3	0.91	91	69.5801	59.1597
2025	4	15	6	13	9	12	0.3	3.3	0.92	91.8	69.5801	59.8027
2025	4	15	6	23	9	12.2	0.3	3.3	0.94	91.4	69.5801	61.3032
2025	4	15	6	33	9	12.4	0.3	3.3	0.91	91.9	69.5801	59.3741
2025	4	15	6	43	9	12.6	0.3	3.3	0.95	95	69.5801	61.5176
2025	4	15	6	53	9	12.8	0.3	3.3	0.87	90.9	69.5801	56.5876
2025	4	15	7	3	9	13	0.3	3.3	0.88	92.1	69.5801	57.6593
2025	4	15	7	13	9	13	0.3	3.3	0.89	91.7	69.5801	58.3024
2025	4	15	7	23	9	13.2	0.3	3.3	0.88	92.8	69.5801	57.445
2025	4	15	7	33	9	13	0.3	3.3	0.91	90.2	69.5801	59.3741
2025	4	15	7	43	9	13	0.3	3.3	0.92	92.9	69.5801	60.0171
2025	4	15	7	53	9	13	0.3	3.3	0.91	91.9	69.5801	59.5884

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	15	8	3	9	13.2	0.3	3.3	0.91	91	69.5801	59.374
2025	4	15	8	13	9	13.2	0.3	3.3	0.91	93.7	69.6457	59.4324
2025	4	15	8	23	9	13.2	0.3	3.3	0.91	90.4	69.6457	59.6469
2025	4	15	8	33	9	13.2	0.3	3.3	0.86	92.2	69.6457	55.9994
2025	4	15	8	43	9	13.2	0.3	3.3	0.9	92.7	69.6457	59.0031
2025	4	15	8	53	9	13.2	0.3	3.3	0.92	91.8	69.6457	60.2904
2025	4	15	9	3	9	13.2	0.3	3.3	0.93	93.4	69.6457	60.934
2025	4	15	9	13	9	13.2	0.3	3.3	0.9	91.5	69.6457	58.5738
2025	4	15	9	23	9	13.2	0.3	3.3	0.91	91	69.6457	59.6465
2025	4	15	9	33	9	13.2	0.3	3.3	0.93	90.2	69.6457	60.5047
2025	4	15	9	43	9	13.2	0.3	3.3	0.89	90.4	69.6457	58.1445
2025	4	15	9	53	9	13.2	0.3	3.3	0.91	91	69.5144	59.5291
2025	4	15	10	3	9	13.2	0.3	3.3	0.92	90.8	69.5801	59.8019
2025	4	15	10	13	9	13.2	0.3	3.3	0.92	92.5	69.5144	59.9572
2025	4	15	10	23	9	13.2	0.3	3.3	0.92	92	69.5801	60.0161
2025	4	15	10	33	9	13.2	0.3	3.3	0.92	92.2	69.4488	60.1119
2025	4	15	10	43	9	13.2	0.3	3.3	0.94	91.4	69.3832	61.3349
2025	4	15	10	53	9	13.4	0.3	3.3	0.93	93.2	69.5144	60.8133
2025	4	15	11	3	9	13.2	0.3	3.3	0.94	92.6	69.5144	61.4556
2025	4	15	11	13	9	13.2	0.3	3.3	0.93	91.4	69.5144	60.3849
2025	4	15	11	23	9	13.2	0.3	3.3	0.9	91.3	69.5144	58.4576
2025	4	15	11	33	9	13.2	0.3	3.3	0.96	91.8	69.5801	62.3732
2025	4	15	11	43	9	13.2	0.3	3.3	0.94	92.4	69.4488	60.9669
2025	4	15	11	53	9	13.2	0.3	3.3	0.9	89.2	69.5144	58.8856
2025	4	15	12	3	9	13.2	0.3	3.3	0.94	90.8	69.5144	61.2409
2025	4	15	12	13	9	13.2	0.3	3.3	0.91	92.5	69.5144	59.3137
2025	4	15	12	23	9	13.2	0.3	3.3	0.92	90.4	69.4488	59.683
2025	4	15	12	33	9	13.2	0.3	3.3	0.95	90	69.5144	62.0971
2025	4	15	12	43	9	13.2	0.3	3.3	0.93	91.8	69.5801	60.4435
2025	4	15	12	53	9	13.2	0.3	3.3	0.91	92.1	69.5144	59.0992
2025	4	15	13	3	9	13	0.3	3	0.91	93.7	69.5144	59.0991
2025	4	15	13	13	9	13.2	0.3	3	0.93	93.6	69.5144	60.598
2025	4	15	13	23	9	13.2	0.3	3	0.92	93.9	69.5144	59.9556
2025	4	15	13	33	9	13.2	0.3	3	0.92	90	69.5144	59.7414
2025	4	15	13	43	9	13.2	0.3	3	0.91	91	69.5801	59.5858
2025	4	15	13	53	9	13.2	0.3	3	0.88	89.4	69.5144	57.6001
2025	4	15	14	3	9	13.2	0.3	3	0.95	91.2	69.5144	61.8826
2025	4	15	14	13	9	13.2	0.3	3	0.91	90.8	69.5144	59.0989
2025	4	15	14	23	9	13.2	0.3	3	0.91	92.5	69.5144	59.5271
2025	4	15	14	33	9	13.2	0.3	3	0.9	90.6	69.5144	58.8847
2025	4	15	14	43	9	13.2	0.3	3	0.89	92.7	69.5144	58.2424
2025	4	15	14	53	9	13.2	0.3	3	0.9	92.7	69.5801	58.7283
2025	4	15	15	3	9	13.2	0.3	3	0.94	92.8	69.6457	61.1461
2025	4	15	15	13	9	13.2	0.3	3	0.89	91.7	69.5801	58.0853
2025	4	15	15	23	9	13.2	0.3	3	0.94	91.4	69.5144	61.0259
2025	4	15	15	33	9	13.2	0.3	3	0.92	91.8	69.5801	60.0143
2025	4	15	15	43	9	13.2	0.3	3	0.86	93.1	69.5801	56.1562
2025	4	15	15	53	9	13.2	0.3	3	0.95	92.4	69.6457	62.2187

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	15	16	3	9	13.2	0.3	3	0.95	91	69.6457	61.7896
2025	4	15	16	13	9	13.2	0.3	3	0.96	91.4	69.5801	62.3719
2025	4	15	16	23	9	13.2	0.3	3	0.91	92.9	69.6457	59.215
2025	4	15	16	33	9	13.2	0.3	3	0.95	93.7	69.5801	62.1575
2025	4	15	16	43	9	12.4	0.3	3	0.91	92.5	69.5801	59.3711
2025	4	15	16	53	9	12.2	0.3	3	0.95	92	69.5801	61.7288
2025	4	15	17	3	9	12.2	0.3	3	0.94	90	69.5144	61.0257
2025	4	15	17	13	9	12.2	0.3	3	0.93	91.6	69.5144	60.3833
2025	4	15	17	23	9	12.2	0.3	3	0.89	90.8	69.5144	58.2421
2025	4	15	17	33	9	12.2	0.3	3	0.91	92.7	69.5144	59.3127
2025	4	15	17	43	9	12.2	0.3	3	0.93	91.8	69.5801	60.6571
2025	4	15	17	53	9	12.2	0.3	3	0.91	91.2	69.5801	59.1568
2025	4	15	18	3	9	12.2	0.3	3	0.92	91	69.5801	60.0142
2025	4	15	18	13	9	12	0.3	3	0.92	91.8	69.5801	60.2285
2025	4	15	18	23	9	12	0.3	3	0.89	93.6	69.5801	58.2995
2025	4	15	18	33	9	12	0.3	3	0.95	91.2	69.5801	61.9433
2025	4	15	18	43	9	12	0.3	3	0.94	93.2	69.5801	61.0859
2025	4	15	18	53	9	12	0.3	3	0.94	90.8	69.6457	61.5751
2025	4	15	19	3	9	12	0.3	3	0.93	93.4	69.5801	60.6573
2025	4	15	19	13	9	12	0.3	3	0.89	90.8	69.5144	58.0282
2025	4	15	19	23	9	12	0.3	3	0.92	92	69.5801	60.0144
2025	4	15	19	33	9	12	0.3	3	0.93	91	69.5801	60.6574
2025	4	15	19	43	9	12	0.3	3	0.94	93.2	69.5801	61.0861
2025	4	15	19	53	9	12	0.3	3	0.95	91.6	69.5801	62.1579
2025	4	15	20	3	9	12	0.3	3	0.92	89	69.5801	60.2289
2025	4	15	20	13	9	12	0.3	3	0.93	92.2	69.5801	60.8719
2025	4	15	20	23	9	12	0.3	3	0.9	91.9	69.5801	58.7285
2025	4	15	20	33	9	12	0.3	3	0.94	89.2	69.5801	61.515
2025	4	15	20	43	9	12	0.3	3	0.94	90	69.5801	61.3007
2025	4	15	20	53	9	12	0.3	3	0.92	92.5	69.5144	59.7415
2025	4	15	21	3	9	12	0.3	3	0.92	90.8	69.5144	60.1698
2025	4	15	21	13	9	12	0.3	3	0.9	91.5	69.5144	58.4568
2025	4	15	21	23	9	12	0.3	3.3	0.9	93.4	69.5144	58.4569
2025	4	15	21	33	9	12	0.3	3.3	0.92	90.8	69.5144	59.9558
2025	4	15	21	43	9	12	0.3	3.3	0.92	92.2	69.5144	59.9558
2025	4	15	21	53	9	12	0.3	3.3	0.89	93.4	69.5144	58.2428
2025	4	15	22	3	9	12	0.3	3.3	0.92	90.8	69.5144	59.9559
2025	4	15	22	13	9	12	0.3	3.3	0.93	92.8	69.5144	60.3842
2025	4	15	22	23	9	12	0.3	3.3	0.93	93.7	69.5144	60.3842
2025	4	15	22	33	9	12	0.3	3.3	0.94	91.8	69.5144	61.4549
2025	4	15	22	43	9	12	0.3	3.3	0.9	88.5	69.5144	58.6713
2025	4	15	22	53	9	12	0.3	3.3	0.91	91.7	69.5144	59.3137
2025	4	15	23	3	9	12	0.3	3.3	0.93	92.2	69.5801	60.6582
2025	4	15	23	13	9	12	0.3	3.3	0.92	93.1	69.5801	60.2295
2025	4	15	23	23	9	12	0.3	3.3	0.91	91.4	69.5144	59.3139
2025	4	15	23	33	9	12	0.3	3.3	0.94	92.6	69.5144	61.0269
2025	4	15	23	43	9	12	0.3	3.3	0.93	92.4	69.5144	60.8128
2025	4	15	23	53	9	12	0.3	3.3	0.89	91.3	69.5144	57.8151

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	16	0	3	9	12	0.3	3.3	0.96	91.8	69.5144	62.3118
2025	4	16	0	13	9	12	0.3	3.3	0.89	91.9	69.5801	57.872
2025	4	16	0	23	9	12	0.3	3.3	0.91	91.9	69.5801	59.1581
2025	4	16	0	33	9	12	0.3	3.3	0.89	92.9	69.5801	58.3008
2025	4	16	0	43	9	12	0.3	3.3	0.92	94.1	69.5801	60.0156
2025	4	16	0	53	9	11.8	0.3	3.3	0.9	92.1	69.5801	58.9439
2025	4	16	1	3	9	11.8	0.3	3.3	0.93	93	69.5801	60.4443
2025	4	16	1	13	9	11.8	0.3	3.3	0.9	95.4	69.5801	58.7296
2025	4	16	1	23	9	11.8	0.3	3.3	0.96	92.2	69.5801	62.3735
2025	4	16	1	33	9	11.8	0.3	3.3	0.9	90	69.5801	58.944
2025	4	16	1	43	9	11.8	0.3	3.3	0.9	91.5	69.5801	58.7297
2025	4	16	1	53	9	11.8	0.3	3.3	0.96	91.8	69.5801	62.3736
2025	4	16	2	3	9	11.8	0.3	3.3	0.91	90.8	69.5801	59.5872
2025	4	16	2	13	9	11.8	0.3	3.3	0.95	90.4	69.5801	62.3736
2025	4	16	2	23	9	11.8	0.3	3.3	0.93	91.8	69.5801	60.4446
2025	4	16	2	33	9	11.8	0.3	3.3	0.9	92.1	69.5801	58.9442
2025	4	16	2	43	9	11.8	0.3	3.3	0.89	91.9	69.5801	58.3012
2025	4	16	2	53	9	11.8	0.3	3.3	0.92	92.6	69.5801	60.2303
2025	4	16	3	3	9	11.8	0.3	3.3	0.92	93.3	69.5801	60.2304
2025	4	16	3	13	9	11.8	0.3	3.3	0.9	90.8	69.5801	58.9443
2025	4	16	3	23	9	11.8	0.3	3.3	0.88	90.6	69.5801	57.444
2025	4	16	3	33	9	11.8	0.3	3.3	0.91	92.5	69.5801	59.3731
2025	4	16	3	43	9	11.8	0.3	3.3	0.91	91.7	69.5801	59.3731
2025	4	16	3	53	9	11.8	0.3	3.3	0.93	91.6	69.5801	60.4448
2025	4	16	4	3	9	11.8	0.3	3.3	0.9	91.9	69.5801	58.7301
2025	4	16	4	13	9	11.8	0.3	3.3	0.91	90.8	69.5801	59.3732
2025	4	16	4	23	9	11.8	0.3	3.3	0.94	92.8	69.5801	61.5166
2025	4	16	4	33	9	11.8	0.3	3.3	0.89	90.4	69.5801	58.3015
2025	4	16	4	43	9	11.8	0.3	3.3	0.93	92.4	69.5801	60.6593
2025	4	16	4	53	9	11.8	0.3	3.3	0.9	94.4	69.5801	58.7302
2025	4	16	5	3	9	11.8	0.3	3.3	0.9	91.9	69.5801	58.9446
2025	4	16	5	13	9	11.8	0.3	3.3	0.93	90.8	69.5801	60.8737
2025	4	16	5	23	9	11.8	0.3	3.3	0.91	93.3	69.4488	59.2566
2025	4	16	5	33	9	11.8	0.3	3.3	0.88	91.1	69.5801	57.2299
2025	4	16	5	43	9	11.8	0.3	3.3	0.88	91.5	69.5801	57.2299
2025	4	16	5	53	9	11.8	0.3	3.3	0.89	92.1	69.5801	57.8729
2025	4	16	6	3	9	11.8	0.3	3.3	0.91	92.7	69.5801	59.159
2025	4	16	6	13	9	11.8	0.3	3.3	0.92	92.3	69.5801	59.8021
2025	4	16	6	23	9	11.8	0.3	3.3	0.94	92.6	69.5801	61.0881
2025	4	16	6	33	9	11.8	0.3	3.3	0.91	93.7	69.5801	59.159
2025	4	16	6	43	9	12	0.3	3.3	0.9	91.3	69.5144	58.6726
2025	4	16	6	53	9	12	0.3	3.3	0.9	93.8	69.5801	58.516
2025	4	16	7	3	9	12	0.3	3.3	0.92	91.8	69.5144	59.9574
2025	4	16	7	13	9	12.2	0.3	3.3	0.9	92.7	69.4488	58.8288
2025	4	16	7	23	9	12.4	0.3	3.3	0.91	94.1	69.5144	59.5291
2025	4	16	7	33	9	12.6	0.3	3.3	0.87	93	69.5144	56.5312
2025	4	16	7	43	9	13	0.3	3.3	0.89	92.7	69.5144	58.2443
2025	4	16	7	53	9	13	0.3	3.3	0.9	93.6	69.5144	58.4583

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	16	8	3	9	13	0.3	3.3	0.94	92.6	69.4488	60.9678
2025	4	16	8	13	9	13	0.3	3.3	0.9	92.7	69.4488	58.8286
2025	4	16	8	23	9	13	0.3	3.3	0.89	92.9	69.4488	58.1868
2025	4	16	8	33	9	13	0.3	3.3	0.91	94.5	69.4488	59.4703
2025	4	16	8	43	9	13	0.3	3.3	0.87	92.8	69.4488	56.9032
2025	4	16	8	53	9	13.2	0.3	3.3	0.97	92.5	69.3832	63.0447
2025	4	16	9	3	9	13.2	0.3	3.3	0.88	91.7	69.3832	57.4881
2025	4	16	9	13	9	13.2	0.3	3.3	0.9	90.6	69.3832	58.5566
2025	4	16	9	23	9	13.2	0.3	3.3	0.92	91.8	69.3832	60.0525
2025	4	16	9	33	9	13.2	0.3	3.3	0.91	91.9	69.3176	59.3527
2025	4	16	9	43	9	13.2	0.3	3.3	0.91	93.7	69.3176	58.9257
2025	4	16	9	53	9	13.2	0.3	3.3	0.92	90	69.3832	59.6249
2025	4	16	10	3	9	13.2	0.3	3.3	0.91	92.3	69.3832	59.4111
2025	4	16	10	13	9	13.2	0.3	3.3	0.91	89.2	69.3832	59.1973
2025	4	16	10	23	9	13.2	0.3	3.3	0.88	92.4	69.3832	57.2738
2025	4	16	10	33	9	13.2	0.3	3.3	0.89	91.3	69.3832	57.7012
2025	4	16	10	43	9	13.2	0.3	3.3	0.91	90.2	69.3832	58.9833
2025	4	16	10	53	9	13.2	0.3	3.3	0.91	92.5	69.3832	59.197
2025	4	16	11	3	9	13.2	0.3	3.3	0.89	90.6	69.3832	57.7009
2025	4	16	11	13	9	13.2	0.3	3.3	0.9	92.9	69.3832	58.5557
2025	4	16	11	23	9	13.2	0.3	3.3	0.94	93.4	69.3832	61.3338
2025	4	16	11	33	9	13.2	0.3	3.3	0.92	92.5	69.3832	59.624
2025	4	16	11	43	9	13.2	0.3	3	0.92	92.9	69.4488	59.6827
2025	4	16	11	53	9	13.2	0.3	3	0.92	93.9	69.3832	59.6239
2025	4	16	12	3	9	13.2	0.3	3	0.92	91.4	69.4488	59.6826
2025	4	16	12	13	9	13.2	0.3	3	0.9	93.7	69.4488	58.8268
2025	4	16	12	23	9	13	0.3	3	0.91	93.7	69.4488	59.2546
2025	4	16	12	33	9	13	0.3	3	0.93	91	69.4488	60.5381
2025	4	16	12	43	9	13.2	0.3	3	0.93	91.6	69.4488	60.3241
2025	4	16	12	53	9	13.2	0.3	3	0.91	90.4	69.4488	59.4684
2025	4	16	13	3	9	13.2	0.3	3	0.88	90.6	69.4488	57.5432
2025	4	16	13	13	9	13.2	0.3	3	0.91	92.7	69.5144	59.3129
2025	4	16	13	23	9	13.4	0.3	3	0.9	91.9	69.5144	58.6705
2025	4	16	13	33	9	13.4	0.3	3	0.94	91.4	69.4488	61.1797
2025	4	16	13	43	9	13.4	0.3	3	0.93	93	69.4488	60.538
2025	4	16	13	53	9	13.4	0.3	3	0.92	92.4	69.4488	60.1102
2025	4	16	14	3	9	13.2	0.3	3	0.89	92.1	69.4488	57.7571
2025	4	16	14	13	9	13.6	0.3	3	0.92	89.4	69.6457	60.2878
2025	4	16	14	23	9	13.6	0.3	3	0.97	90.8	69.5144	63.1671
2025	4	16	14	33	9	13.6	0.3	3	0.91	92.3	69.5144	59.0987
2025	4	16	14	43	9	13.6	0.3	3	0.92	91.4	69.5144	60.1694
2025	4	16	14	53	9	13.6	0.3	3	0.91	93.1	69.5144	59.527
2025	4	16	15	3	9	13.6	0.3	3	0.92	92.3	69.5144	59.7411
2025	4	16	15	13	9	13.8	0.3	3	0.93	92.6	69.5144	60.3835
2025	4	16	15	23	9	13.4	0.3	3	0.9	91.9	69.5144	58.6704
2025	4	16	15	33	9	12.6	0.3	3	0.88	91.1	69.5144	57.1716
2025	4	16	15	43	9	12.4	0.3	3	0.92	93.7	69.5144	59.7411
2025	4	16	15	53	9	12.4	0.3	3	0.89	91.5	69.5144	58.2422

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	16	16	3	9	12.2	0.3	3	0.93	90.4	69.5144	60.5976
2025	4	16	16	13	9	12.2	0.3	3	0.92	90.8	69.5144	59.9552
2025	4	16	16	23	9	12.2	0.3	3	0.9	91	69.5801	58.9426
2025	4	16	16	33	9	12.2	0.3	3	0.94	91.8	69.5144	61.0259
2025	4	16	16	43	9	12.2	0.3	3	0.91	90	69.6457	59.2151
2025	4	16	16	53	9	12.2	0.3	3	0.94	91.4	69.5144	61.2401
2025	4	16	17	3	9	12.2	0.3	3	0.94	91.6	69.5144	61.026
2025	4	16	17	13	9	12.2	0.3	3	0.92	91	69.5144	59.9554
2025	4	16	17	23	9	12.2	0.3	3	0.94	91	69.5144	61.026
2025	4	16	17	33	9	12.2	0.3	3	0.92	93.3	69.5144	59.9554
2025	4	16	17	43	9	12.2	0.3	3	0.9	92.1	69.5144	58.8848
2025	4	16	17	53	9	12.2	0.3	3	0.94	94.6	69.4488	60.966
2025	4	16	18	3	9	12.2	0.3	3	0.93	92.6	69.5144	60.812
2025	4	16	18	13	9	12.2	0.3	3	0.91	92.9	69.5144	59.5273
2025	4	16	18	23	9	12.2	0.3	3	0.92	94.1	69.5144	60.1697
2025	4	16	18	33	9	12.2	0.3	3	0.93	90.2	69.5144	60.8121
2025	4	16	18	43	9	12.2	0.3	3	0.89	91.1	69.5801	58.2999
2025	4	16	18	53	9	12.2	0.3	3	0.9	91.7	69.5144	58.885
2025	4	16	19	3	9	12.2	0.3	3	0.91	91.7	69.5144	59.3133
2025	4	16	19	13	9	12	0.3	3	0.94	93.6	69.5144	61.0264
2025	4	16	19	23	9	12	0.3	3.3	0.93	93.4	69.5144	60.8123
2025	4	16	19	33	9	12	0.3	3.3	0.91	90.6	69.5144	59.3134
2025	4	16	19	43	9	12	0.3	3.3	0.88	92.3	69.5801	57.6571
2025	4	16	19	53	9	12	0.3	3.3	0.95	91.8	69.5801	62.1583
2025	4	16	20	3	9	12	0.3	3.3	0.92	92.5	69.5801	59.8006
2025	4	16	20	13	9	12	0.3	3.3	0.93	93	69.5801	60.4436
2025	4	16	20	23	9	12	0.3	3.3	0.92	90.2	69.6457	60.074
2025	4	16	20	33	9	12	0.3	3.3	0.92	90.8	69.5801	60.2294
2025	4	16	20	43	9	12	0.3	3.3	0.94	93	69.5801	61.5154
2025	4	16	20	53	9	12	0.3	3.3	0.89	90.2	69.5144	58.243
2025	4	16	21	3	9	12	0.3	3.3	0.92	91.6	69.6457	60.0741
2025	4	16	21	13	9	12	0.3	3.3	0.93	92.8	69.6457	60.5032
2025	4	16	21	23	9	12	0.3	3.3	0.9	91.7	69.7113	58.6299
2025	4	16	21	33	9	12	0.3	3.3	0.92	92.1	69.7113	59.9185
2025	4	16	21	43	9	12	0.3	3.3	0.91	89.6	69.7113	59.489
2025	4	16	21	53	9	12	0.3	3.3	0.92	93.3	69.7113	60.1333
2025	4	16	22	3	9	12	0.3	3.3	0.93	91.8	69.7113	60.7776
2025	4	16	22	13	9	12	0.3	3.3	0.92	93.7	69.7113	60.1333
2025	4	16	22	23	9	12	0.3	3.3	0.92	90.2	69.7113	60.1334
2025	4	16	22	33	9	12	0.3	3.3	0.96	93.1	69.7113	62.4958
2025	4	16	22	43	9	12	0.3	3.3	0.88	90.4	69.7113	57.771
2025	4	16	22	53	9	12	0.3	3.3	0.93	91	69.7113	60.9925
2025	4	16	23	3	9	12	0.3	3.3	0.92	91.2	69.7113	60.3482
2025	4	16	23	13	9	12	0.3	3.3	0.92	91.4	69.7113	60.1335
2025	4	16	23	23	9	12	0.3	3.3	0.93	90.8	69.7113	60.5631
2025	4	16	23	33	9	12	0.3	3.3	0.9	92.9	69.7113	58.845
2025	4	16	23	43	9	12	0.3	3.3	0.93	90.8	69.7113	60.9927
2025	4	16	23	53	9	12	0.3	3.3	0.94	91.8	69.7113	61.4222

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	17	0	3	9	12	0.3	3.3	0.92	93.7	69.5801	60.23
2025	4	17	0	13	9	12	0.3	3.3	0.93	91	69.6457	60.5038
2025	4	17	0	23	9	12	0.3	3.3	0.92	89.8	69.6457	60.2893
2025	4	17	0	33	9	12	0.3	3.3	0.91	93.1	69.6457	59.6456
2025	4	17	0	43	9	12	0.3	3.3	0.93	93	69.6457	60.7184
2025	4	17	0	53	9	12	0.3	3.3	0.92	95.1	69.6457	60.0748
2025	4	17	1	3	9	12	0.3	3.3	0.92	92	69.6457	60.0748
2025	4	17	1	13	9	12	0.3	3.3	0.95	93.4	69.6457	62.2204
2025	4	17	1	23	9	12	0.3	3.3	0.93	91.8	69.6457	60.7185
2025	4	17	1	33	9	12	0.3	3.3	0.88	93.6	69.6457	57.7148
2025	4	17	1	43	9	12	0.3	3.3	0.96	92.4	69.6457	62.435
2025	4	17	1	53	9	12	0.3	3.3	0.94	91	69.6457	61.1477
2025	4	17	2	3	9	12	0.3	3.3	0.91	92.1	69.6457	59.6459
2025	4	17	2	13	9	11.8	0.3	3.3	0.91	91.7	69.6457	59.4313
2025	4	17	2	23	9	11.8	0.3	3.3	0.94	92.6	69.6457	61.5769
2025	4	17	2	33	9	11.8	0.3	3.3	0.91	92.7	69.6457	59.6459
2025	4	17	2	43	9	11.8	0.3	3.3	0.93	94.1	69.6457	60.5042
2025	4	17	2	53	9	11.8	0.3	3.3	0.89	91.9	69.6457	58.1441
2025	4	17	3	3	9	11.8	0.3	3.3	0.92	91	69.6457	60.2897
2025	4	17	3	13	9	11.8	0.3	3.3	0.91	91.9	69.6457	59.4315
2025	4	17	3	23	9	11.8	0.3	3.3	0.9	93.1	69.6457	59.0024
2025	4	17	3	33	9	11.8	0.3	3.3	0.89	92.1	69.6457	58.3587
2025	4	17	3	43	9	11.8	0.3	3.3	0.91	94.1	69.6457	59.6461
2025	4	17	3	53	9	11.8	0.3	3.3	0.92	91.4	69.6457	60.0752
2025	4	17	4	3	9	11.8	0.3	3.3	0.91	92.5	69.6457	59.217
2025	4	17	4	13	9	11.8	0.3	3.3	0.92	92	69.6457	60.0753
2025	4	17	4	23	9	11.8	0.3	3.3	0.9	91	69.6457	58.5734
2025	4	17	4	33	9	11.8	0.3	3.3	0.89	90.2	69.5801	58.3016
2025	4	17	4	43	9	11.8	0.3	3.3	0.93	90	69.6457	60.9336
2025	4	17	4	53	9	11.8	0.3	3.3	0.93	91.8	69.6457	60.9336
2025	4	17	5	3	9	11.8	0.3	3.3	0.93	91	69.6457	60.7191
2025	4	17	5	13	9	11.8	0.3	3.3	0.88	92.8	69.6457	57.2862
2025	4	17	5	23	9	11.8	0.3	3.3	0.93	91.8	69.5801	60.8738
2025	4	17	5	33	9	11.8	0.3	3.3	0.92	92.2	69.5801	60.0165
2025	4	17	5	43	9	11.8	0.3	3.3	0.91	95.2	69.5801	59.1591
2025	4	17	5	53	9	11.8	0.3	3.3	0.94	92	69.5801	61.0882
2025	4	17	6	3	9	11.8	0.3	3.3	0.9	91.2	69.6457	59.0028
2025	4	17	6	13	9	11.8	0.3	3.3	0.9	91.9	69.5801	58.9448
2025	4	17	6	23	9	11.8	0.3	3.3	0.9	92.1	69.5801	58.9449
2025	4	17	6	33	9	12	0.3	3.3	0.87	92.4	69.5801	56.5871
2025	4	17	6	43	9	12	0.3	3.3	0.91	90.8	69.5801	59.1592
2025	4	17	6	53	9	12	0.3	3.3	0.9	92.3	69.5801	58.9449
2025	4	17	7	3	9	12.2	0.3	3.3	0.89	92.9	69.5801	58.3019
2025	4	17	7	13	9	12.2	0.3	3.3	0.91	92.5	69.5801	59.5879
2025	4	17	7	23	9	12.2	0.3	3.3	0.9	91	69.5801	58.7306
2025	4	17	7	33	9	12.2	0.3	3.3	0.89	92.5	69.5801	58.0875
2025	4	17	7	43	9	12.6	0.3	3.3	0.89	93.2	69.5801	58.0875
2025	4	17	7	53	9	12.8	0.3	3.3	0.91	93.7	69.5801	59.3736

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	17	8	3	9	13	0.3	3.3	0.91	92.5	69.5801	59.1592
2025	4	17	8	13	9	12.8	0.3	3.3	0.9	92.3	69.6457	59.0028
2025	4	17	8	23	9	12.8	0.3	3.3	0.92	91.4	69.6457	59.861
2025	4	17	8	33	9	13.6	0.3	3.3	0.93	92	69.5801	60.6596
2025	4	17	8	43	9	13.6	0.3	3.3	0.94	91.2	69.6457	61.5774
2025	4	17	8	53	9	13.8	0.3	3.3	0.88	91.7	69.6457	57.2863
2025	4	17	9	3	9	13.6	0.3	3.3	0.91	93.5	69.6457	59.6463
2025	4	17	9	13	9	13.4	0.3	3.3	0.9	93.8	69.6457	58.788
2025	4	17	9	23	9	13.4	0.3	3.3	0.9	92.5	69.6457	58.5734
2025	4	17	9	33	9	13.4	0.3	3.3	0.93	93	69.6457	60.7189
2025	4	17	9	43	9	13.4	0.3	3.3	0.93	93.6	69.6457	60.7189
2025	4	17	9	53	9	13.4	0.3	3.3	0.89	91.5	69.6457	58.3587
2025	4	17	10	3	9	13.4	0.3	3.3	0.87	90.4	69.6457	56.8567
2025	4	17	10	13	9	13.4	0.3	3.3	0.94	92.2	69.6457	61.5768
2025	4	17	10	23	9	13.4	0.3	3.3	0.94	91.2	69.6457	61.3622
2025	4	17	10	33	9	13.4	0.3	3.3	0.94	92.6	69.6457	61.1475
2025	4	17	10	43	9	13.4	0.3	3.3	0.92	93.5	69.6457	59.8601
2025	4	17	10	53	9	13.4	0.3	3.3	0.9	91.7	69.6457	58.5727
2025	4	17	11	3	9	13.4	0.3	3.3	0.93	92	69.6457	60.5036
2025	4	17	11	13	9	13.4	0.3	3.3	0.92	90.8	69.6457	60.0744
2025	4	17	11	23	9	13.4	0.3	3.3	0.92	93.1	69.6457	60.0743
2025	4	17	11	33	9	13.4	0.3	3.3	0.91	93.3	69.6457	59.216
2025	4	17	11	43	9	13.4	0.3	3.3	0.94	91.8	69.6457	61.1469
2025	4	17	11	53	9	13.2	0.3	3.3	0.91	91.6	69.5801	59.5864
2025	4	17	12	3	9	13.2	0.3	3.3	0.9	89.6	69.5801	58.5146
2025	4	17	12	13	9	13.2	0.3	3.3	0.93	91.4	69.5144	60.3841
2025	4	17	12	23	9	13.2	0.3	3.3	0.91	94.5	69.5144	59.3134
2025	4	17	12	33	9	13.2	0.3	3	0.91	91.9	69.5144	59.3133
2025	4	17	12	43	9	13.2	0.3	3	0.93	93	69.5144	60.8121
2025	4	17	12	53	9	13.2	0.3	3	0.94	91.4	69.5144	61.2402
2025	4	17	13	3	9	13.2	0.3	3	0.94	90	69.5144	61.2402
2025	4	17	13	13	9	13.2	0.3	3	0.93	92.2	69.5801	60.8717
2025	4	17	13	23	9	13.2	0.3	3	0.86	89.1	69.5801	56.3706
2025	4	17	13	33	9	12.8	0.3	3	0.92	90.2	69.6457	59.8587
2025	4	17	13	43	9	12.6	0.3	3	0.91	91	69.5801	59.5856
2025	4	17	13	53	9	12.8	0.3	3	0.91	91.9	69.6457	59.4296
2025	4	17	14	3	9	13.2	0.3	3	0.95	90.2	69.5801	61.9433
2025	4	17	14	13	9	13.8	0.3	3	0.95	91.2	69.5801	62.1576
2025	4	17	14	23	9	13.8	0.3	3	0.92	91.6	69.5801	59.7999
2025	4	17	14	33	9	13.8	0.3	3	0.92	90.6	69.5801	59.7999
2025	4	17	14	43	9	13.8	0.3	3	0.94	90.8	69.7113	61.8502
2025	4	17	14	53	9	13.6	0.3	3	0.95	93.4	69.6457	62.2186
2025	4	17	15	3	9	13.6	0.3	3	0.95	91.4	69.7113	62.2797
2025	4	17	15	13	9	13.6	0.3	3	0.95	91	69.7113	62.0649
2025	4	17	15	23	9	13.6	0.3	3	0.93	91.6	69.7769	60.621
2025	4	17	15	33	9	13.6	0.3	3	0.9	89.8	69.6457	58.7858
2025	4	17	15	43	9	13.6	0.3	3	0.98	92.7	69.7113	63.9977
2025	4	17	15	53	9	13.6	0.3	3	0.97	91.7	69.7769	63.4156

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	17	16	3	9	13.6	0.3	3	0.91	92.3	69.6457	59.2148
2025	4	17	16	13	9	13.4	0.3	3	0.97	91.7	69.7113	63.5681
2025	4	17	16	23	9	13.2	0.3	3	0.9	91.9	69.7769	58.6862
2025	4	17	16	33	9	13.8	0.3	3	0.87	92.4	69.7113	57.1253
2025	4	17	16	43	9	13.8	0.3	3	0.95	90.6	69.7769	62.1257
2025	4	17	16	53	9	13.8	0.3	3	0.93	93	69.7769	60.6209
2025	4	17	17	3	9	13.6	0.3	3	0.93	93.4	69.7769	60.8359
2025	4	17	17	13	9	12.6	0.3	3	0.93	93.4	69.7113	60.5615
2025	4	17	17	23	9	12.4	0.3	3	0.9	91.7	69.7113	58.8434
2025	4	17	17	33	9	12.4	0.3	3	0.92	91.8	69.6457	60.073
2025	4	17	17	43	9	12.2	0.3	3	0.91	92.3	69.7113	59.273
2025	4	17	17	53	9	12.2	0.3	3	0.93	90.8	69.6457	60.9312
2025	4	17	18	3	9	12.2	0.3	3	0.92	92.9	69.6457	60.073
2025	4	17	18	13	9	12.2	0.3	3	0.94	91.6	69.6457	61.5749
2025	4	17	18	23	9	12.2	0.3	3	0.9	92.9	69.7113	58.6288
2025	4	17	18	33	9	12.2	0.3	3	0.93	90.8	69.7113	60.5616
2025	4	17	18	43	9	12.2	0.3	3	0.94	93.2	69.7113	61.6355
2025	4	17	18	53	9	12.2	0.3	3	0.92	90.4	69.7113	60.1322
2025	4	17	19	3	9	12.2	0.3	3	0.97	90.2	69.7769	63.4158
2025	4	17	19	13	9	12.2	0.3	3	0.93	90	69.7769	61.0512
2025	4	17	19	23	9	12.2	0.3	3	0.91	92.5	69.8425	59.3896
2025	4	17	19	33	9	12.2	0.3	3	0.93	89.8	69.8425	60.6807
2025	4	17	19	43	9	12.2	0.3	3	0.92	92	69.9081	60.3094
2025	4	17	19	53	9	12.2	0.3	3	0.93	91.4	69.9081	61.171
2025	4	17	20	3	9	12.2	0.3	3	0.95	91	69.9081	62.6788
2025	4	17	20	13	9	12.2	0.3	3	0.92	92.4	69.9081	60.5249
2025	4	17	20	23	9	12.2	0.3	3	0.91	93.7	69.9081	59.448
2025	4	17	20	33	9	12	0.3	3	0.94	92.2	69.9081	61.8174
2025	4	17	20	43	9	12	0.3	3	0.92	91.6	69.9081	60.3097
2025	4	17	20	53	9	12	0.3	3	0.94	92.6	69.9081	61.3867
2025	4	17	21	3	9	12	0.3	3.3	0.91	90.6	69.9081	59.6636
2025	4	17	21	13	9	12	0.3	3.3	0.93	92.8	69.9081	60.956
2025	4	17	21	23	9	12	0.3	3.3	0.97	93.3	69.9081	63.7562
2025	4	17	21	33	9	12	0.3	3.3	0.9	91	69.9081	59.0176
2025	4	17	21	43	9	12	0.3	3.3	0.92	93.5	69.9081	60.5254
2025	4	17	21	53	9	12	0.3	3.3	0.89	89.2	69.9081	58.587
2025	4	17	22	3	9	12	0.3	3.3	0.93	90	69.9081	61.1717
2025	4	17	22	13	9	12	0.3	3.3	0.96	91	69.9081	63.1104
2025	4	17	22	23	9	12	0.3	3.3	0.97	90.6	69.9081	63.5412
2025	4	17	22	33	9	12	0.3	3.3	0.9	91.5	69.9081	59.018
2025	4	17	22	43	9	12	0.3	3.3	0.94	90.6	69.9081	61.3874
2025	4	17	22	53	9	12	0.3	3.3	0.9	93.8	69.9081	59.0181
2025	4	17	23	3	9	12	0.3	3.3	0.95	93.6	69.8425	62.1882
2025	4	17	23	13	9	12	0.3	3.3	0.93	92	69.9081	60.7414
2025	4	17	23	23	9	12	0.3	3.3	0.93	90	69.8425	61.1123
2025	4	17	23	33	9	12	0.3	3.3	0.92	93.7	69.8425	60.0365
2025	4	17	23	43	9	12	0.3	3.3	0.93	90.4	69.9081	60.9569
2025	4	17	23	53	9	12	0.3	3.3	0.92	92.6	69.8425	60.4669

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	18	0	3	9	12	0.3	3.3	0.91	91.9	69.8425	59.8214
2025	4	18	0	13	9	12	0.3	3.3	0.97	92.1	69.8425	63.2645
2025	4	18	0	23	9	12	0.3	3.3	0.9	91.9	69.8425	59.176
2025	4	18	0	33	9	12	0.3	3.3	0.91	92.9	69.8425	59.8216
2025	4	18	0	43	9	12	0.3	3.3	0.93	91.4	69.8425	60.6824
2025	4	18	0	53	9	12	0.3	3.3	0.92	92.2	69.8425	60.4672
2025	4	18	1	3	9	12	0.3	3.3	0.93	91.6	69.8425	60.6824
2025	4	18	1	13	9	12	0.3	3.3	0.92	92.6	69.8425	60.4673
2025	4	18	1	23	9	12	0.3	3.3	0.92	91.2	69.8425	60.4673
2025	4	18	1	33	9	12	0.3	3.3	0.99	91.7	69.8425	64.9863
2025	4	18	1	43	9	12	0.3	3.3	0.92	91	69.8425	60.4674
2025	4	18	1	53	9	12	0.3	3.3	0.9	90.8	69.8425	59.1764
2025	4	18	2	3	9	12	0.3	3.3	0.91	92.5	69.8425	59.3916
2025	4	18	2	13	9	12	0.3	3.3	0.88	90	69.8425	57.6702
2025	4	18	2	23	9	12	0.3	3.3	0.95	93.4	69.7769	61.9132
2025	4	18	2	33	9	12	0.3	3.3	0.94	93	69.8425	61.5436
2025	4	18	2	43	9	12	0.3	3.3	0.89	92.5	69.7769	58.0438
2025	4	18	2	53	9	12	0.3	3.3	0.94	94.4	69.7769	61.2684
2025	4	18	3	3	9	12	0.3	3.3	0.93	92.6	69.7769	61.0535
2025	4	18	3	13	9	12	0.3	3.3	0.92	92.1	69.8425	60.0375
2025	4	18	3	23	9	12	0.3	3.3	0.92	94.5	69.7769	60.1937
2025	4	18	3	33	9	12	0.3	3.3	0.93	92.2	69.7769	60.8387
2025	4	18	3	43	9	12	0.3	3.3	0.92	91.2	69.7769	59.9788
2025	4	18	3	53	9	12	0.3	3.3	0.89	89.8	69.7769	58.474
2025	4	18	4	3	9	11.8	0.3	3.3	0.93	90.8	69.7769	60.8388
2025	4	18	4	13	9	11.8	0.3	3.3	0.9	91.5	69.7769	58.689
2025	4	18	4	23	9	11.8	0.3	3.3	0.95	92.6	69.7769	62.1287
2025	4	18	4	33	9	11.8	0.3	3.3	0.91	93.3	69.7769	59.764
2025	4	18	4	43	9	11.8	0.3	3.3	0.9	91.5	69.7769	58.9041
2025	4	18	4	53	9	11.8	0.3	3.3	0.92	93.3	69.7769	60.194
2025	4	18	5	3	9	11.8	0.3	3.3	0.93	91	69.7769	61.0539
2025	4	18	5	13	9	11.8	0.3	3.3	0.93	94.4	69.7769	60.839
2025	4	18	5	23	9	11.8	0.3	3.3	0.86	91.1	69.7769	56.5394
2025	4	18	5	33	9	11.8	0.3	3.3	0.95	92	69.7769	62.1289
2025	4	18	5	43	9	11.8	0.3	3.3	0.9	91.9	69.7769	59.1193
2025	4	18	5	53	9	11.8	0.3	3.3	0.91	93.1	69.7769	59.3343
2025	4	18	6	3	9	12	0.3	3.3	0.92	92.2	69.7769	60.1942
2025	4	18	6	13	9	12	0.3	3.3	0.92	91.4	69.7769	59.9793
2025	4	18	6	23	9	12.2	0.3	3.3	0.95	92.6	69.8425	62.4052
2025	4	18	6	33	9	12.4	0.3	3.3	0.94	92.8	69.8425	61.5445
2025	4	18	6	43	9	12.6	0.3	3.3	0.92	92.7	69.8425	60.2534
2025	4	18	6	53	9	12.8	0.3	3.3	0.94	93.2	69.9081	61.6049
2025	4	18	7	3	9	12.8	0.3	3.3	0.91	91	69.8425	59.6079
2025	4	18	7	13	9	12.8	0.3	3.3	0.9	92.3	69.8425	59.1776
2025	4	18	7	23	9	13	0.3	3.3	0.92	90.8	69.8425	60.2536
2025	4	18	7	33	9	13	0.3	3.3	0.92	93.5	69.8425	60.2536
2025	4	18	7	43	9	13	0.3	3.3	0.92	92.7	69.9081	60.0972
2025	4	18	7	53	9	13.2	0.3	3.3	0.95	91.8	69.8425	62.1903

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	18	8	3	9	13.2	0.3	3.3	0.93	92	69.9081	60.7434
2025	4	18	8	13	9	13.2	0.3	3.3	0.93	90	69.9081	60.7434
2025	4	18	8	23	9	13.4	0.3	3.3	0.92	93.5	69.8425	60.4688
2025	4	18	8	33	9	13.6	0.3	3.3	0.9	93.4	69.8425	58.7473
2025	4	18	8	43	9	13.8	0.3	3.3	0.92	91	69.8425	60.2536
2025	4	18	8	53	9	13.8	0.3	3.3	0.87	93.7	69.8425	57.2409
2025	4	18	9	3	9	13.8	0.3	3.3	0.92	91.4	69.9081	60.3126
2025	4	18	9	13	9	13.8	0.3	3.3	0.93	92.6	69.8425	61.1143
2025	4	18	9	23	9	13.8	0.3	3.3	0.98	92.1	69.8425	63.9117
2025	4	18	9	33	9	13.8	0.3	3.3	0.94	92.6	69.8425	61.3294
2025	4	18	9	43	9	13.8	0.3	3.3	0.94	91	69.9081	61.8202
2025	4	18	9	53	9	13.8	0.3	3.3	0.92	93.5	69.9081	60.097
2025	4	18	10	3	9	13.8	0.3	3.3	0.93	93.7	69.8425	60.6837
2025	4	18	10	13	9	13.8	0.3	3.3	0.93	93.7	69.9081	60.7431
2025	4	18	10	23	9	13.8	0.3	3.3	0.94	90	69.8425	61.9747
2025	4	18	10	33	9	13.8	0.3	3.3	0.94	94.2	69.8425	61.329
2025	4	18	10	43	9	13.8	0.3	3.3	0.92	92.6	69.8425	60.4682
2025	4	18	10	53	9	13.8	0.3	3.3	0.94	92.6	69.9081	61.389
2025	4	18	11	3	9	14	0.3	3.3	0.91	95.4	69.8425	59.3921
2025	4	18	11	13	9	13.8	0.3	3.3	0.93	91.2	69.8425	60.8984
2025	4	18	11	23	9	13.8	0.3	3.3	0.95	92.8	69.8425	61.9742
2025	4	18	11	33	9	13.8	0.3	3.3	0.92	91	69.8425	60.4678
2025	4	18	11	43	9	13.8	0.3	3.3	0.93	90	69.7769	61.0534
2025	4	18	11	53	9	13.8	0.3	3.3	0.92	92	69.8425	60.4677
2025	4	18	12	3	9	13.8	0.3	3.3	0.95	92.8	69.8425	62.4043
2025	4	18	12	13	9	13.8	0.3	3.3	0.94	91.8	69.8425	61.5434
2025	4	18	12	23	9	13.8	0.3	3.3	0.94	93	69.8425	61.3282
2025	4	18	12	33	9	13.8	0.3	3.3	0.93	92	69.8425	60.8977
2025	4	18	12	43	9	13.8	0.3	3.3	0.96	92.2	69.8425	62.8343
2025	4	18	12	53	9	13.8	0.3	3.3	0.91	91.9	69.8425	59.6065
2025	4	18	13	3	9	13.6	0.3	3.3	0.96	93.5	69.8425	62.8342
2025	4	18	13	13	9	13.6	0.3	3.3	0.94	91.8	69.8425	61.543
2025	4	18	13	23	9	13.4	0.3	3.3	0.97	92.5	69.8425	63.2644
2025	4	18	13	33	9	13.8	0.3	3.3	0.9	91	69.9081	59.2338
2025	4	18	13	43	9	13.8	0.3	3.3	0.96	91.4	69.8425	62.8339
2025	4	18	13	53	9	13.8	0.3	3.3	0.9	90.8	69.8425	59.1757
2025	4	18	14	3	9	13.8	0.3	3.3	0.92	90.8	69.7769	59.9776
2025	4	18	14	13	9	13.8	0.3	3.3	0.97	92.5	69.8425	63.2641
2025	4	18	14	23	9	13.8	0.3	3.3	0.94	91.2	69.8425	61.5426
2025	4	18	14	33	9	13.8	0.3	3.3	0.98	94.2	69.8425	64.34
2025	4	18	14	43	9	13.8	0.3	3.3	0.89	93.8	69.8425	58.3148
2025	4	18	14	53	9	13.8	0.3	3.3	0.92	91.2	69.8425	60.4666
2025	4	18	15	3	9	13.8	0.3	3.3	0.92	90.2	69.8425	60.4666
2025	4	18	15	13	9	13.8	0.3	3.3	0.93	92.4	69.7769	61.0522
2025	4	18	15	23	9	13.8	0.3	3.3	0.92	91.2	69.7769	60.1923
2025	4	18	15	33	9	13.8	0.3	3.3	0.92	91	69.8425	60.4665
2025	4	18	15	43	9	13.8	0.3	3.3	0.92	92	69.7769	60.1923
2025	4	18	15	53	9	13.8	0.3	3.3	0.95	91.4	69.7769	62.342

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	18	16	3	9	13.8	0.3	3.3	0.92	90.6	69.7769	60.1923
2025	4	18	16	13	9	13.8	0.3	3.3	0.96	94.5	69.8425	62.8335
2025	4	18	16	23	9	13.4	0.3	3.3	0.92	91.6	69.8425	60.2513
2025	4	18	16	33	9	13.4	0.3	3.3	0.94	90.2	69.7769	61.2672
2025	4	18	16	43	9	13.4	0.3	3.3	0.93	91.2	69.7769	60.8373
2025	4	18	16	53	9	13.4	0.3	3.3	0.94	91.2	69.7769	61.4822
2025	4	18	17	3	9	13	0.3	3.3	0.93	92.8	69.7769	61.0523
2025	4	18	17	13	9	12.4	0.3	3.3	0.93	90	69.7769	61.0523
2025	4	18	17	23	9	12.4	0.3	3.3	0.92	91.8	69.7769	60.1925
2025	4	18	17	33	9	12.4	0.3	3.3	0.95	90.2	69.8425	62.6186
2025	4	18	17	43	9	12.2	0.3	3.3	0.95	91.8	69.7769	62.1274
2025	4	18	17	53	9	12.2	0.3	3.3	0.93	91.8	69.8425	60.8972
2025	4	18	18	3	9	12.2	0.3	3.3	0.91	92.9	69.7769	59.3328
2025	4	18	18	13	9	12.2	0.3	3.3	0.92	90	69.8425	60.467
2025	4	18	18	23	9	12.2	0.3	3.3	0.91	92.9	69.8425	59.8215
2025	4	18	18	33	9	12.2	0.3	3.3	0.89	93	69.8425	58.3153
2025	4	18	18	43	9	12.2	0.3	3.3	0.95	93.6	69.7769	62.3427
2025	4	18	18	53	9	12.2	0.3	3.3	0.95	92	69.7769	62.3428
2025	4	18	19	3	9	12.2	0.3	3.3	0.93	90.6	69.7769	60.6231
2025	4	18	19	13	9	12.2	0.3	3.3	0.94	91.4	69.7769	61.2681
2025	4	18	19	23	9	12.2	0.3	3.3	0.9	92.1	69.7769	58.6884
2025	4	18	19	33	9	12.2	0.3	3.3	0.94	91.8	69.7769	61.4832
2025	4	18	19	43	9	12.2	0.3	3.3	0.93	90.6	69.7769	61.0533
2025	4	18	19	53	9	12	0.3	3.3	0.95	92.2	69.7769	62.1282
2025	4	18	20	3	9	12	0.3	3.3	0.92	92.9	69.7769	59.9785
2025	4	18	20	13	9	12	0.3	3.3	0.91	91.7	69.7113	59.4903
2025	4	18	20	23	9	12	0.3	3.3	0.94	90.8	69.7113	61.2084
2025	4	18	20	33	9	12	0.3	3.3	0.97	93.5	69.7113	63.5709
2025	4	18	20	43	9	12	0.3	3.3	0.96	91.4	69.7113	62.4972
2025	4	18	20	53	9	12	0.3	3.3	0.92	91.8	69.7113	60.1348
2025	4	18	21	3	9	12	0.3	3.3	0.93	92	69.7113	60.9939
2025	4	18	21	13	9	12	0.3	3.3	0.94	91.6	69.7113	61.6383
2025	4	18	21	23	9	12	0.3	3.3	0.92	94.3	69.7113	60.135
2025	4	18	21	33	9	12	0.3	3.3	0.93	91.8	69.6457	60.5051
2025	4	18	21	43	9	12	0.3	3.3	0.94	93.2	69.6457	61.1489
2025	4	18	21	53	9	12	0.3	3.3	0.91	93.7	69.6457	59.647
2025	4	18	22	3	9	12	0.3	3.3	0.92	92.1	69.6457	59.8617
2025	4	18	22	13	9	12	0.3	3.3	0.94	93.6	69.6457	61.1491
2025	4	18	22	23	9	12	0.3	3.3	0.93	91.6	69.6457	60.72
2025	4	18	22	33	9	12	0.3	3.3	0.91	92.3	69.6457	59.6473
2025	4	18	22	43	9	12	0.3	3.3	0.92	93.5	69.6457	60.0764
2025	4	18	22	53	9	12	0.3	3.3	0.94	92.2	69.6457	61.3639
2025	4	18	23	3	9	12	0.3	3.3	0.92	93.3	69.6457	59.862
2025	4	18	23	13	9	12	0.3	3.3	0.92	92.7	69.6457	59.8621
2025	4	18	23	23	9	12	0.3	3.3	0.93	92.4	69.6457	60.5058
2025	4	18	23	33	9	12	0.3	3.3	0.89	93	69.6457	58.1457
2025	4	18	23	43	9	12	0.3	3.3	0.93	93.2	69.6457	60.935
2025	4	18	23	53	9	12	0.3	3.3	0.94	92.6	69.5801	61.5183

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	19	0	3	9	12	0.3	3.3	0.91	93.1	69.6457	59.4332
2025	4	19	0	13	9	12	0.3	3.3	0.96	92	69.6457	62.4371
2025	4	19	0	23	9	12	0.3	3.3	0.91	93.7	69.6457	59.6479
2025	4	19	0	33	9	12	0.3	3.3	0.93	92	69.5801	60.4468
2025	4	19	0	43	9	12	0.3	3.3	0.92	91.8	69.6457	60.2917
2025	4	19	0	53	9	12	0.3	3.3	0.9	93.5	69.5801	58.9464
2025	4	19	1	3	9	12	0.3	3.3	0.91	93.3	69.5801	59.3752
2025	4	19	1	13	9	12	0.3	3.3	0.89	91.9	69.5801	58.3035
2025	4	19	1	23	9	12	0.3	3.3	0.94	93	69.5801	61.3044
2025	4	19	1	33	9	12	0.3	3.3	0.91	93.5	69.5801	59.161
2025	4	19	1	43	9	12	0.3	3.3	0.93	94.3	69.5801	60.4471
2025	4	19	1	53	9	12	0.3	3.3	0.92	93.3	69.5801	59.8041
2025	4	19	2	3	9	12	0.3	3.3	0.94	90.8	69.5801	61.7333
2025	4	19	2	13	9	12	0.3	3.3	0.92	91.8	69.5801	59.8042
2025	4	19	2	23	9	12	0.3	3.3	0.96	93.3	69.6457	62.4378
2025	4	19	2	33	9	12	0.3	3.3	0.95	93.4	69.6457	61.7942
2025	4	19	2	43	9	12	0.3	3.3	0.92	93.1	69.6457	60.2923
2025	4	19	2	53	9	11.8	0.3	3.3	0.94	94.2	69.6457	61.5797
2025	4	19	3	3	9	11.8	0.3	3.3	0.88	93.2	69.7113	57.7743
2025	4	19	3	13	9	11.8	0.3	3.3	0.91	94.1	69.7113	59.2777
2025	4	19	3	23	9	11.8	0.3	3.3	0.92	93.9	69.7113	60.1369
2025	4	19	3	33	9	11.8	0.3	3.3	0.89	92.7	69.7769	58.476
2025	4	19	3	43	9	11.8	0.3	3.3	0.9	92.5	69.7769	58.906
2025	4	19	3	53	9	11.8	0.3	3.3	0.93	93.7	69.7769	60.626
2025	4	19	4	3	9	11.8	0.3	3.3	0.9	91	69.8425	58.9639
2025	4	19	4	13	9	11.8	0.3	3.3	0.92	92.9	69.8425	60.2551
2025	4	19	4	23	9	11.8	0.3	3.3	0.92	90.8	69.8425	60.2551
2025	4	19	4	33	9	11.8	0.3	3.3	0.91	93.7	69.8425	59.6096
2025	4	19	4	43	9	11.8	0.3	3.3	0.94	92.4	69.8425	61.3312
2025	4	19	4	53	9	11.8	0.3	3.3	0.92	91.8	69.8425	60.2552
2025	4	19	5	3	9	11.8	0.3	3.3	0.93	93.2	69.8425	60.9009
2025	4	19	5	13	9	11.8	0.3	3.3	0.95	93.8	69.8425	62.1921
2025	4	19	5	23	9	11.8	0.3	3.3	0.91	93.9	69.8425	59.3946
2025	4	19	5	33	9	11.8	0.3	3.3	0.93	91.2	69.8425	60.901
2025	4	19	5	43	9	11.8	0.3	3.3	0.91	90.8	69.8425	59.3947
2025	4	19	5	53	9	11.8	0.3	3.3	0.91	91.9	69.8425	59.3947
2025	4	19	6	3	9	12	0.3	3.3	0.9	92.7	69.8425	58.9643
2025	4	19	6	13	9	12	0.3	3.3	0.9	91.2	69.8425	59.1796
2025	4	19	6	23	9	12.2	0.3	3.3	0.9	92.7	69.8425	58.7492
2025	4	19	6	33	9	12.6	0.3	3.3	0.92	94.1	69.8425	60.0404
2025	4	19	6	43	9	12.8	0.3	3.3	0.96	91	69.8425	62.838
2025	4	19	6	53	9	13	0.3	3.3	0.93	90.2	69.8425	61.1164
2025	4	19	7	3	9	13	0.3	3.3	0.93	92.4	69.8425	61.1164
2025	4	19	7	13	9	13	0.3	3.3	0.92	89.4	69.8425	60.4708
2025	4	19	7	23	9	13.2	0.3	3.3	0.95	93.4	69.8425	61.9772
2025	4	19	7	33	9	13.2	0.3	3.3	0.94	92	69.8425	61.762
2025	4	19	7	43	9	13.4	0.3	3.3	0.9	94	69.8425	59.1796
2025	4	19	7	53	9	13.2	0.3	3.3	0.93	95.9	69.8425	60.6859

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	19	8	3	9	13.2	0.3	3.3	0.91	92.9	69.7769	59.3365
2025	4	19	8	13	9	13.4	0.3	3.3	0.94	93.4	69.8425	61.3315
2025	4	19	8	23	9	13.6	0.3	3.3	0.97	93.5	69.8425	63.4834
2025	4	19	8	33	9	13.6	0.3	3.3	0.93	93.8	69.8425	60.901
2025	4	19	8	43	9	13.4	0.3	3.3	0.92	92.9	69.7769	60.4113
2025	4	19	8	53	9	13.4	0.3	3.3	0.93	93.4	69.8425	60.9009
2025	4	19	9	3	9	13.4	0.3	3.3	0.94	92.2	69.8425	61.3312
2025	4	19	9	13	9	13.8	0.3	3.3	0.91	92.1	69.8425	59.3943
2025	4	19	9	23	9	13.8	0.3	3.3	0.93	92.8	69.8425	60.6855
2025	4	19	9	33	9	13.8	0.3	3.3	0.94	93.6	69.7769	61.7009
2025	4	19	9	43	9	13.8	0.3	3.3	0.94	91.4	69.8425	61.5461
2025	4	19	9	53	9	13.8	0.3	3.3	0.94	92.8	69.7769	61.2707
2025	4	19	10	3	9	13.8	0.3	3.3	0.92	92.1	69.8425	60.0395
2025	4	19	10	13	9	13.8	0.3	3.3	0.91	92.7	69.7769	59.7657
2025	4	19	10	23	9	13.8	0.3	3.3	0.93	92.6	69.7113	60.5661
2025	4	19	10	33	9	13.8	0.3	3.3	0.89	94.5	69.7113	57.7739
2025	4	19	10	43	9	13.8	0.3	3.3	0.94	93.6	69.7113	61.425
2025	4	19	10	53	9	13.8	0.3	3.3	0.96	91.8	69.6457	62.4374
2025	4	19	11	3	9	13.8	0.3	3.3	0.89	93.8	69.6457	57.9315
2025	4	19	11	13	9	13.8	0.3	3.3	0.9	92.5	69.6457	58.5751
2025	4	19	11	23	9	13.8	0.3	3.3	0.9	94.4	69.6457	58.7895
2025	4	19	11	33	9	13.6	0.3	3.3	0.9	91.5	69.6457	59.004
2025	4	19	11	43	9	13.6	0.3	3.3	0.92	95.1	69.7113	60.1357
2025	4	19	11	53	9	13.8	0.3	3.3	0.96	92.5	69.7113	62.9276
2025	4	19	12	3	9	13.6	0.3	3.3	0.91	92.3	69.7113	59.7059
2025	4	19	12	13	9	13.6	0.3	3.3	0.93	91	69.7113	60.5649
2025	4	19	12	23	9	13.6	0.3	3.3	0.92	92.9	69.6457	60.2908
2025	4	19	12	33	9	13.6	0.3	3.3	0.95	93.2	69.7113	62.2828
2025	4	19	12	43	9	13.6	0.3	3.3	0.93	93	69.7113	60.5646
2025	4	19	12	53	9	13.6	0.3	3.3	0.96	91	69.7113	62.7122
2025	4	19	13	3	9	13.6	0.3	3.3	0.95	93.6	69.7113	62.2825
2025	4	19	13	13	9	13.6	0.3	3.3	0.89	91.5	69.7113	57.9871
2025	4	19	13	23	9	13.6	0.3	3.3	0.94	94.8	69.7113	61.638
2025	4	19	13	33	9	13.6	0.3	3.3	0.92	92.3	69.7113	59.9198
2025	4	19	13	43	9	13.6	0.3	3.3	0.93	91.4	69.7113	60.7788
2025	4	19	13	53	9	13.6	0.3	3.3	0.94	91.4	69.7113	61.2082
2025	4	19	14	3	9	13.6	0.3	3.3	0.91	92.9	69.7113	59.2752
2025	4	19	14	13	9	13.6	0.3	3.3	0.91	92.7	69.7769	59.3333
2025	4	19	14	23	9	13.6	0.3	3.3	0.95	93.6	69.7769	61.913
2025	4	19	14	33	9	13.6	0.3	3.3	0.91	93.1	69.7113	59.4898
2025	4	19	14	43	9	13.6	0.3	3.3	0.94	92.6	69.7113	61.4226
2025	4	19	14	53	9	13.6	0.3	3.3	0.91	92.9	69.7769	59.763
2025	4	19	15	3	9	13.6	0.3	3.3	0.93	92.2	69.7769	61.0528
2025	4	19	15	13	9	13.6	0.3	3.3	0.97	93.1	69.7769	63.2025
2025	4	19	15	23	9	13.6	0.3	3.3	0.94	91	69.7113	61.6371
2025	4	19	15	33	9	13.6	0.3	3.3	0.92	92.9	69.7113	59.919
2025	4	19	15	43	9	13.4	0.3	3.3	0.93	92.4	69.7769	60.8376
2025	4	19	15	53	9	13.4	0.3	3.3	0.93	93.6	69.7769	60.8376

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	19	16	3	9	13.6	0.3	3.3	0.95	93.2	69.7113	61.8517
2025	4	19	16	13	9	13.6	0.3	3.3	0.93	92.8	69.7769	60.6226
2025	4	19	16	23	9	13.6	0.3	3.3	0.93	91.8	69.6457	60.9328
2025	4	19	16	33	9	13.6	0.3	3.3	0.97	91.9	69.7113	63.355
2025	4	19	16	43	9	13.6	0.3	3.3	0.92	92.6	69.7769	60.4076
2025	4	19	16	53	9	13.2	0.3	3.3	0.91	93.3	69.6457	59.6454
2025	4	19	17	3	9	12.8	0.3	3.3	0.93	91.2	69.7113	60.9926
2025	4	19	17	13	9	12.4	0.3	3.3	0.93	93	69.7113	60.5631
2025	4	19	17	23	9	12.4	0.3	3.3	0.96	93.5	69.7113	62.7107
2025	4	19	17	33	9	12.4	0.3	3.3	0.95	93.4	69.7113	61.8517
2025	4	19	17	43	9	12.2	0.3	3.3	0.91	94.4	69.7769	59.3327
2025	4	19	17	53	9	12.2	0.3	3.3	0.92	92.9	69.7113	60.3484
2025	4	19	18	3	9	12.2	0.3	3.3	0.94	92.2	69.7113	61.4222
2025	4	19	18	13	9	12.2	0.3	3.3	0.95	93.4	69.7113	61.8518
2025	4	19	18	23	9	12.2	0.3	3.3	0.89	92.1	69.7769	58.043
2025	4	19	18	33	9	12.2	0.3	3.3	0.91	93.9	69.7769	59.3328
2025	4	19	18	43	9	12.2	0.3	3.3	0.95	92	69.7769	62.3425
2025	4	19	18	53	9	12.2	0.3	3.3	0.94	92.2	69.7769	61.6976
2025	4	19	19	3	9	12.2	0.3	3.3	0.91	91.9	69.7769	59.7629
2025	4	19	19	13	9	12.2	0.3	3.3	0.92	93.7	69.7113	60.3486
2025	4	19	19	23	9	12.2	0.3	3.3	0.92	92.5	69.7113	60.1339
2025	4	19	19	33	9	12.2	0.3	3.3	0.94	94	69.7113	61.2077
2025	4	19	19	43	9	12.2	0.3	3.3	0.93	91.8	69.7769	60.8379
2025	4	19	19	53	9	12.2	0.3	3.3	0.92	90.6	69.7769	60.408
2025	4	19	20	3	9	12.2	0.3	3.3	0.91	91	69.7769	59.7631
2025	4	19	20	13	9	12	0.3	3.3	0.89	91.9	69.7769	58.4733
2025	4	19	20	23	9	12	0.3	3.3	0.95	90.8	69.7769	62.3429
2025	4	19	20	33	9	12	0.3	3.3	0.91	91.9	69.7769	59.3332
2025	4	19	20	43	9	12	0.3	3.3	0.91	90.8	69.7769	59.5483
2025	4	19	20	53	9	12	0.3	3.3	0.9	93.6	69.7769	58.6884
2025	4	19	21	3	9	12	0.3	3.3	0.94	92.6	69.7113	61.2081
2025	4	19	21	13	9	12	0.3	3.3	0.95	94.2	69.7113	62.0672
2025	4	19	21	23	9	12	0.3	3.3	0.92	92.7	69.7113	60.1343
2025	4	19	21	33	9	12	0.3	3.3	0.92	91	69.7113	60.3491
2025	4	19	21	43	9	12	0.3	3.3	0.9	92.1	69.7113	59.0606
2025	4	19	21	53	9	12	0.3	3.3	0.92	92.3	69.7113	59.9197
2025	4	19	22	3	9	12	0.3	3.3	0.89	93.8	69.7113	57.9868
2025	4	19	22	13	9	12	0.3	3.3	0.93	91.8	69.7113	60.9936
2025	4	19	22	23	9	12	0.3	3.3	0.92	93.3	69.7113	60.1346
2025	4	19	22	33	9	12	0.3	3.3	0.93	92.6	69.7113	60.5642
2025	4	19	22	43	9	12	0.3	3.3	0.89	92.5	69.7113	58.2018
2025	4	19	22	53	9	12	0.3	3.3	0.92	93.1	69.6457	60.2903
2025	4	19	23	3	9	12	0.3	3.3	0.92	90	69.6457	59.8612
2025	4	19	23	13	9	12	0.3	3.3	0.92	92.4	69.6457	60.2904
2025	4	19	23	23	9	12	0.3	3.3	0.95	91.2	69.6457	62.436
2025	4	19	23	33	9	12	0.3	3.3	0.92	91.4	69.6457	59.8614
2025	4	19	23	43	9	12	0.3	3.3	0.91	90.6	69.6457	59.6468
2025	4	19	23	53	9	12	0.3	3.3	0.89	92.8	69.6457	57.9304

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	20	0	3	9	12	0.3	3.3	0.94	92	69.6457	61.578
2025	4	20	0	13	9	12	0.3	3.3	0.89	91.5	69.6457	58.1451
2025	4	20	0	23	9	12	0.3	3.3	0.97	92.9	69.6457	63.08
2025	4	20	0	33	9	12	0.3	3.3	0.91	91.9	69.5801	59.1598
2025	4	20	0	43	9	12	0.3	3.3	0.92	94.1	69.5801	59.8029
2025	4	20	0	53	9	12	0.3	3.3	0.92	90.4	69.5801	59.8029
2025	4	20	1	3	9	12	0.3	3.3	0.89	91.1	69.5801	58.3025
2025	4	20	1	13	9	12	0.3	3.3	0.89	91.9	69.5801	58.3026
2025	4	20	1	23	9	12	0.3	3.3	0.92	93.5	69.5801	59.8031
2025	4	20	1	33	9	12	0.3	3.3	0.89	91.5	69.5801	58.0883
2025	4	20	1	43	9	12	0.3	3.3	0.9	91.5	69.5801	58.7314
2025	4	20	1	53	9	12	0.3	3.3	0.92	92.5	69.5801	60.0175
2025	4	20	2	3	9	12	0.3	3.3	0.93	91.8	69.5801	60.4463
2025	4	20	2	13	9	12	0.3	3.3	0.93	91.8	69.5801	60.875
2025	4	20	2	23	9	12	0.3	3.3	0.92	92.6	69.5801	60.232
2025	4	20	2	33	9	12	0.3	3.3	0.91	92.7	69.5801	59.3746
2025	4	20	2	43	9	11.8	0.3	3.3	0.9	91.5	69.5144	58.6739
2025	4	20	2	53	9	11.8	0.3	3.3	0.93	91.2	69.5144	60.8153
2025	4	20	3	3	9	11.8	0.3	3.3	0.88	93.6	69.5144	57.6033
2025	4	20	3	13	9	11.8	0.3	3.3	0.9	92.7	69.5144	58.674
2025	4	20	3	23	9	11.8	0.3	3.3	0.93	91.6	69.5144	60.8154
2025	4	20	3	33	9	11.8	0.3	3.3	0.93	92.6	69.5144	60.6013
2025	4	20	3	43	9	11.8	0.3	3.3	0.93	91.8	69.5144	60.6014
2025	4	20	3	53	9	11.8	0.3	3.3	0.93	92.2	69.5144	60.3873
2025	4	20	4	3	9	11.8	0.3	3.3	0.92	91.6	69.5144	60.1732
2025	4	20	4	13	9	11.8	0.3	3.3	0.92	91.8	69.5144	59.9591
2025	4	20	4	23	9	11.8	0.3	3.3	0.93	94.5	69.5144	60.3874
2025	4	20	4	33	9	11.8	0.3	3.3	0.92	92.7	69.5144	59.745
2025	4	20	4	43	9	11.8	0.3	3.3	0.93	91.6	69.5144	60.3875
2025	4	20	4	53	9	11.8	0.3	3.3	0.91	92.3	69.5144	59.3168
2025	4	20	5	3	9	11.8	0.3	3.3	0.95	92.8	69.5144	61.8865
2025	4	20	5	13	9	11.8	0.3	3.3	0.91	91.9	69.5144	59.1027
2025	4	20	5	23	9	11.8	0.3	3.3	0.92	91.8	69.5144	59.9593
2025	4	20	5	33	9	11.8	0.3	3.3	0.92	92.9	69.5144	59.9594
2025	4	20	5	43	9	11.8	0.3	3.3	0.92	90.6	69.5144	59.9594
2025	4	20	5	53	9	11.8	0.3	3.3	0.92	91.8	69.5144	59.9594
2025	4	20	6	3	9	12	0.3	3.3	0.89	91.9	69.5144	58.0322
2025	4	20	6	13	9	12.2	0.3	3.3	0.94	91.8	69.5144	61.2443
2025	4	20	6	23	9	12.4	0.3	3.3	0.92	92.6	69.5144	60.1737
2025	4	20	6	33	9	12.6	0.3	3.3	0.94	94	69.5144	61.2444
2025	4	20	6	43	9	12.8	0.3	3.3	0.9	91.7	69.5144	58.6747
2025	4	20	6	53	9	13	0.3	3.3	0.92	92.7	69.5144	59.7454
2025	4	20	7	3	9	13	0.3	3.3	0.93	90.8	69.5144	60.8161
2025	4	20	7	13	9	13.2	0.3	3.3	0.94	92.4	69.5144	61.0303
2025	4	20	7	23	9	13.2	0.3	3.3	0.92	92.9	69.5144	59.7454
2025	4	20	7	33	9	13.4	0.3	3.3	0.92	94.5	69.5144	59.7454
2025	4	20	7	43	9	13.4	0.3	3.3	0.94	92	69.5144	61.0302
2025	4	20	7	53	9	13.2	0.3	3.3	0.92	91.6	69.5144	59.9595

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	20	8	3	9	13.2	0.3	3.3	0.95	90.6	69.5144	62.1009
2025	4	20	8	13	9	13.4	0.3	3.3	0.9	93.1	69.5144	58.8887
2025	4	20	8	23	9	13.6	0.3	3.3	0.9	94.8	69.5144	58.4604
2025	4	20	8	33	9	13.6	0.3	3.3	0.92	92.3	69.5144	59.7452
2025	4	20	8	43	9	13.4	0.3	3.3	0.94	92.6	69.5801	61.3044
2025	4	20	8	53	9	13.4	0.3	3.3	0.9	91.3	69.5801	58.7321
2025	4	20	9	3	9	13.4	0.3	3.3	0.95	93.6	69.5801	61.7329
2025	4	20	9	13	9	13.2	0.3	3.3	0.92	92.7	69.5801	59.8037
2025	4	20	9	23	9	13.2	0.3	3.3	0.95	93	69.5801	61.7328
2025	4	20	9	33	9	13.2	0.3	3.3	0.93	92.2	69.5801	60.4466
2025	4	20	9	43	9	13.4	0.3	3.3	0.91	93.5	69.5801	59.3748
2025	4	20	9	53	9	13.4	0.3	3.3	0.93	94.1	69.5801	60.4464
2025	4	20	10	3	9	13.4	0.3	3.3	0.89	93.6	69.5801	57.8742
2025	4	20	10	13	9	13.2	0.3	3.3	0.89	92.8	69.5801	57.8741
2025	4	20	10	23	9	13.4	0.3	3.3	0.92	90.8	69.6457	60.0764
2025	4	20	10	33	9	13.4	0.3	3.3	0.94	93	69.6457	61.1491
2025	4	20	10	43	9	13.4	0.3	3.3	0.93	93	69.6457	60.5054
2025	4	20	10	53	9	13.4	0.3	3.3	0.91	92.5	69.6457	59.2179
2025	4	20	11	3	9	13.4	0.3	3.3	0.88	91.7	69.6457	57.5014
2025	4	20	11	13	9	13.4	0.3	3.3	0.96	91.4	69.6457	62.4361
2025	4	20	11	23	9	13.4	0.3	3.3	0.9	91	69.7113	58.6315
2025	4	20	11	33	9	13.4	0.3	3.3	0.9	91	69.7113	58.8461
2025	4	20	11	43	9	13.4	0.3	3.3	0.92	92.7	69.7113	59.9199
2025	4	20	11	53	9	13.4	0.3	3.3	0.91	91.9	69.7113	59.705
2025	4	20	12	3	9	13.4	0.3	3.3	0.95	91	69.7113	61.8526
2025	4	20	12	13	9	13.4	0.3	3.3	0.95	94.9	69.7113	62.0672
2025	4	20	12	23	9	13.4	0.3	3.3	0.94	91.4	69.7113	61.208
2025	4	20	12	33	9	13.4	0.3	3.3	0.91	93.7	69.7769	59.7632
2025	4	20	12	43	9	13.4	0.3	3.3	0.93	92.4	69.6457	60.5041
2025	4	20	12	53	9	13.4	0.3	3.3	0.93	92.6	69.7113	60.993
2025	4	20	13	3	9	13.4	0.3	3.3	0.91	93.3	69.6457	59.2166
2025	4	20	13	13	9	13.4	0.3	3.3	0.94	93.6	69.7113	61.6371
2025	4	20	13	23	9	13.4	0.3	3.3	0.93	91.8	69.6457	60.9328
2025	4	20	13	33	9	13.4	0.3	3.3	0.92	92.9	69.7113	59.9188
2025	4	20	13	43	9	13.4	0.3	3.3	0.95	93	69.7769	62.1272
2025	4	20	13	53	9	13.4	0.3	3.3	0.92	92	69.7769	60.1924
2025	4	20	14	3	9	13.4	0.3	3.3	0.95	91.4	69.7113	62.2809
2025	4	20	14	13	9	13.4	0.3	3.3	0.93	92.8	69.6457	60.5033
2025	4	20	14	23	9	13.4	0.3	3.3	0.93	91.8	69.7113	60.7775
2025	4	20	14	33	9	13.4	0.3	3.3	0.95	92.6	69.8425	62.1878
2025	4	20	14	43	9	13.2	0.3	3.3	0.93	91.6	69.7113	60.7773
2025	4	20	14	53	9	13.2	0.3	3.3	0.93	91.4	69.7769	61.0519
2025	4	20	15	3	9	13.2	0.3	3.3	0.93	91.8	69.7113	60.5624
2025	4	20	15	13	9	13.2	0.3	3.3	0.94	90.6	69.7113	61.6362
2025	4	20	15	23	9	13.2	0.3	3.3	0.94	93.2	69.8425	61.3268
2025	4	20	15	33	9	13.2	0.3	3.3	0.95	90.2	69.7769	62.3415
2025	4	20	15	43	9	13.4	0.3	3	0.95	91	69.7113	62.0656
2025	4	20	15	53	9	13.4	0.3	3	0.95	92.2	69.8425	62.4025

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	20	16	3	9	13.4	0.3	3	0.96	92.4	69.8425	62.8329
2025	4	20	16	13	9	13.4	0.3	3	0.96	91.8	69.8425	62.6177
2025	4	20	16	23	9	13.4	0.3	3	0.93	91.2	69.7113	60.5622
2025	4	20	16	33	9	13.4	0.3	3	0.97	93.7	69.7113	63.354
2025	4	20	16	43	9	13.4	0.3	3	0.96	92.6	69.7769	62.5563
2025	4	20	16	53	9	13.2	0.3	3	0.91	93.1	69.7113	59.7031
2025	4	20	17	3	9	12.6	0.3	3	0.92	92.4	69.7769	60.4066
2025	4	20	17	13	9	12.4	0.3	3	0.93	90	69.7769	61.0515
2025	4	20	17	23	9	12.4	0.3	3	0.96	92	69.7769	62.7713
2025	4	20	17	33	9	12.4	0.3	3	0.97	94.3	69.7769	63.2013
2025	4	20	17	43	9	12.2	0.3	3	0.95	91.4	69.7769	62.1264
2025	4	20	17	53	9	12.2	0.3	3	0.94	93	69.8425	61.5418
2025	4	20	18	3	9	12.2	0.3	3	0.93	90.8	69.8425	60.8963
2025	4	20	18	13	9	12.2	0.3	3.3	0.94	90.8	69.8425	61.3267
2025	4	20	18	23	9	12.2	0.3	3.3	0.93	91.4	69.8425	61.1115
2025	4	20	18	33	9	12.2	0.3	3.3	0.93	90.2	69.8425	60.6812
2025	4	20	18	43	9	12.2	0.3	3.3	0.95	94.2	69.8425	61.9723
2025	4	20	18	53	9	12.2	0.3	3.3	0.97	90.6	69.8425	63.6938
2025	4	20	19	3	9	12.2	0.3	3.3	0.88	93	69.8425	57.8839
2025	4	20	19	13	9	12.2	0.3	3.3	0.92	91.8	69.8425	60.251
2025	4	20	19	23	9	12.2	0.3	3.3	0.94	90	69.9081	61.8178
2025	4	20	19	33	9	12.2	0.3	3.3	0.96	91.4	69.8425	62.618
2025	4	20	19	43	9	12.2	0.3	3.3	0.93	91.2	69.8425	60.8966
2025	4	20	19	53	9	12.2	0.3	3.3	0.95	92.2	69.8425	61.9726
2025	4	20	20	3	9	12.2	0.3	3.3	0.95	91.6	69.8425	62.403
2025	4	20	20	13	9	12.2	0.3	3.3	0.94	91.6	69.9081	61.6025
2025	4	20	20	23	9	12.2	0.3	3.3	0.95	91	69.8425	61.9727
2025	4	20	20	33	9	12.2	0.3	3.3	0.89	91.3	69.9081	58.1563
2025	4	20	20	43	9	12	0.3	3.3	0.94	92.2	69.9081	61.6026
2025	4	20	20	53	9	12	0.3	3.3	0.92	91	69.9081	60.3103
2025	4	20	21	3	9	12	0.3	3.3	0.95	91.4	69.9081	62.2489
2025	4	20	21	13	9	12	0.3	3.3	0.91	92.9	69.9081	59.4488
2025	4	20	21	23	9	12	0.3	3.3	0.94	91.6	69.9081	61.6028
2025	4	20	21	33	9	12	0.3	3.3	0.93	90.6	69.9081	60.9567
2025	4	20	21	43	9	12	0.3	3.3	0.96	93.3	69.9081	62.8953
2025	4	20	21	53	9	12	0.3	3.3	0.91	90.6	69.9081	59.449
2025	4	20	22	3	9	12	0.3	3.3	0.95	91.2	69.9081	62.68
2025	4	20	22	13	9	12	0.3	3.3	0.95	91.8	69.8425	62.1883
2025	4	20	22	23	9	12	0.3	3.3	0.94	90.8	69.8425	61.758
2025	4	20	22	33	9	12	0.3	3.3	0.92	92.9	69.8425	60.0365
2025	4	20	22	43	9	12	0.3	3.3	0.96	91.2	69.8425	62.834
2025	4	20	22	53	9	12	0.3	3.3	0.93	91.8	69.8425	60.8974
2025	4	20	23	3	9	12	0.3	3.3	0.96	92	69.8425	62.8341
2025	4	20	23	13	9	12	0.3	3.3	0.96	90	69.8425	62.8341
2025	4	20	23	23	9	12	0.3	3.3	0.93	94.4	69.8425	61.1127
2025	4	20	23	33	9	12	0.3	3.3	0.93	90.4	69.8425	60.8976
2025	4	20	23	43	9	12	0.3	3.3	0.92	90	69.8425	60.252
2025	4	20	23	53	9	12	0.3	3.3	0.9	95	69.8425	58.961

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	21	0	3	9	12	0.3	3.3	0.89	91.9	69.8425	58.3155
2025	4	21	0	13	9	12	0.3	3.3	0.94	90.2	69.8425	61.7585
2025	4	21	0	23	9	12	0.3	3.3	0.94	92.8	69.8425	61.5434
2025	4	21	0	33	9	12	0.3	3.3	0.93	91.6	69.7769	60.6232
2025	4	21	0	43	9	12	0.3	3.3	0.9	91.9	69.7769	58.9034
2025	4	21	0	53	9	12	0.3	3.3	0.91	91	69.7769	59.3334
2025	4	21	1	3	9	12	0.3	3.3	0.92	90	69.7769	60.1934
2025	4	21	1	13	9	12	0.3	3.3	0.92	89.2	69.7769	59.9785
2025	4	21	1	23	9	12	0.3	3.3	0.9	91.9	69.7769	59.1186
2025	4	21	1	33	9	12	0.3	3.3	0.92	92.4	69.7769	60.4085
2025	4	21	1	43	9	12	0.3	3.3	0.95	93.2	69.7769	62.3433
2025	4	21	1	53	9	12	0.3	3.3	0.95	93	69.7769	62.1284
2025	4	21	2	3	9	12	0.3	3.3	0.95	91.2	69.7769	61.9134
2025	4	21	2	13	9	12	0.3	3.3	0.94	93.4	69.7769	61.4835
2025	4	21	2	23	9	12	0.3	3.3	0.95	91	69.7769	62.5584
2025	4	21	2	33	9	12	0.3	3.3	0.94	92.6	69.7769	61.2686
2025	4	21	2	43	9	12	0.3	3.3	0.94	90.6	69.7769	61.2686
2025	4	21	2	53	9	12	0.3	3.3	0.89	92.8	69.7769	58.044
2025	4	21	3	3	9	12	0.3	3.3	0.94	92	69.7769	61.4837
2025	4	21	3	13	9	11.8	0.3	3.3	0.93	90.8	69.7769	60.8388
2025	4	21	3	23	9	11.8	0.3	3.3	0.91	91.6	69.7769	59.7639
2025	4	21	3	33	9	11.8	0.3	3.3	0.93	91.4	69.7769	60.6239
2025	4	21	3	43	9	11.8	0.3	3.3	0.91	91.9	69.7113	59.4906
2025	4	21	3	53	9	11.8	0.3	3.3	0.91	91	69.7113	59.2759
2025	4	21	4	3	9	11.8	0.3	3.3	0.94	92	69.7113	61.6384
2025	4	21	4	13	9	11.8	0.3	3.3	0.97	91.9	69.7113	63.3566
2025	4	21	4	23	9	11.8	0.3	3.3	0.94	90.4	69.7113	61.6385
2025	4	21	4	33	9	11.8	0.3	3.3	0.93	92.6	69.7113	60.5646
2025	4	21	4	43	9	11.8	0.3	3.3	0.92	90.2	69.7113	60.1351
2025	4	21	4	53	9	11.8	0.3	3.3	0.94	91.8	69.7113	61.6386
2025	4	21	5	3	9	11.8	0.3	3.3	0.92	91.8	69.7113	59.9204
2025	4	21	5	13	9	11.8	0.3	3.3	0.93	90	69.7113	60.5648
2025	4	21	5	23	9	11.8	0.3	3.3	0.92	92.7	69.7113	59.9205
2025	4	21	5	33	9	11.8	0.3	3.3	0.95	90.2	69.7113	62.4978
2025	4	21	5	43	9	11.8	0.3	3.3	0.94	92.8	69.7113	61.2092
2025	4	21	5	53	9	11.8	0.3	3.3	0.87	92.2	69.7113	57.1286
2025	4	21	6	3	9	12	0.3	3.3	0.91	90.6	69.7113	59.4911
2025	4	21	6	13	9	12.2	0.3	3.3	0.94	92.6	69.7113	61.6388
2025	4	21	6	23	9	12.4	0.3	3.3	0.93	92.8	69.7113	60.7797
2025	4	21	6	33	9	12.6	0.3	3.3	0.91	89.8	69.7113	59.7059
2025	4	21	6	43	9	12.8	0.3	3.3	0.92	91.8	69.7113	59.9207
2025	4	21	6	53	9	12.8	0.3	3.3	0.91	91.6	69.7113	59.7059
2025	4	21	7	3	9	12.8	0.3	3.3	0.92	93.9	69.7113	59.9207
2025	4	21	7	13	9	13	0.3	3.3	0.94	91	69.7113	61.2093
2025	4	21	7	23	9	13	0.3	3.3	0.97	91.9	69.7113	63.357
2025	4	21	7	33	9	13	0.3	3.3	0.93	91.2	69.7113	60.7797
2025	4	21	7	43	9	13	0.3	3.3	0.94	92.4	69.7113	61.2092
2025	4	21	7	53	9	13	0.3	3.3	0.92	93.3	69.7113	60.1354

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	4	21	8	3	9	13	0.3	3.3	0.9	91.7	69.7113	58.6319
2025	4	21	8	13	9	13.2	0.3	3.3	0.94	91.2	69.7113	61.2091
2025	4	21	9	55	46	13.6	0.1	1	28.21	91.4	6.4825	60.6241

Locust Ditch Return
Station 0215

Date	Flow (cfs)
4/1/2025	0
4/2/2025	0
4/3/2025	0
4/4/2025	0
4/5/2025	0
4/6/2025	0
4/7/2025	0
4/8/2025	0
4/9/2025	0
4/10/2025	0
4/11/2025	0
4/12/2025	0
4/13/2025	0
4/14/2025	0
4/15/2025	0
4/16/2025	0
4/17/2025	0
4/18/2025	0
4/19/2025	0
4/20/2025	0
4/21/2025	0
4/22/2025	0
4/23/2025	0
4/24/2025	0
4/25/2025	0
4/26/2025	0
4/27/2025	0
4/28/2025	0
4/29/2025	0
4/30/2025	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/1/2025	12:00:00 AM	0
4/1/2025	12:15:00 AM	0
4/1/2025	12:30:00 AM	0
4/1/2025	12:45:00 AM	0
4/1/2025	1:00:00 AM	0
4/1/2025	1:15:00 AM	0
4/1/2025	1:30:00 AM	0
4/1/2025	1:45:00 AM	0
4/1/2025	2:00:00 AM	0
4/1/2025	2:15:00 AM	0
4/1/2025	2:30:00 AM	0
4/1/2025	2:45:00 AM	0
4/1/2025	3:00:00 AM	0
4/1/2025	3:15:00 AM	0
4/1/2025	3:30:00 AM	0
4/1/2025	3:45:00 AM	0
4/1/2025	4:00:00 AM	0
4/1/2025	4:15:00 AM	0
4/1/2025	4:30:00 AM	0
4/1/2025	4:45:00 AM	0
4/1/2025	5:00:00 AM	0
4/1/2025	5:15:00 AM	0
4/1/2025	5:30:00 AM	0
4/1/2025	5:45:00 AM	0
4/1/2025	6:00:00 AM	0
4/1/2025	6:15:00 AM	0
4/1/2025	6:30:00 AM	0
4/1/2025	6:45:00 AM	0
4/1/2025	7:00:00 AM	0
4/1/2025	7:15:00 AM	0
4/1/2025	7:30:00 AM	0
4/1/2025	7:45:00 AM	0
4/1/2025	8:00:00 AM	0
4/1/2025	8:15:00 AM	0
4/1/2025	8:30:00 AM	0
4/1/2025	8:45:00 AM	0
4/1/2025	9:00:00 AM	0
4/1/2025	9:15:00 AM	0
4/1/2025	9:30:00 AM	0
4/1/2025	9:45:00 AM	0
4/1/2025	10:00:00 AM	0
4/1/2025	10:15:00 AM	0
4/1/2025	10:30:00 AM	0
4/1/2025	10:45:00 AM	0
4/1/2025	11:00:00 AM	0
4/1/2025	11:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/1/2025	11:30:00 AM	0
4/1/2025	11:45:00 AM	0
4/1/2025	12:00:00 PM	0
4/1/2025	12:15:00 PM	0
4/1/2025	12:30:00 PM	0
4/1/2025	12:45:00 PM	0
4/1/2025	1:00:00 PM	0
4/1/2025	1:15:00 PM	0
4/1/2025	1:30:00 PM	0
4/1/2025	1:45:00 PM	0
4/1/2025	2:00:00 PM	0
4/1/2025	2:15:00 PM	0
4/1/2025	2:30:00 PM	0
4/1/2025	2:45:00 PM	0
4/1/2025	3:00:00 PM	0
4/1/2025	3:15:00 PM	0
4/1/2025	3:30:00 PM	0
4/1/2025	3:45:00 PM	0
4/1/2025	4:00:00 PM	0
4/1/2025	4:15:00 PM	0
4/1/2025	4:30:00 PM	0
4/1/2025	4:45:00 PM	0
4/1/2025	5:00:00 PM	0
4/1/2025	5:15:00 PM	0
4/1/2025	5:30:00 PM	0
4/1/2025	5:45:00 PM	0
4/1/2025	6:00:00 PM	0
4/1/2025	6:15:00 PM	0
4/1/2025	6:30:00 PM	0
4/1/2025	6:45:00 PM	0
4/1/2025	7:00:00 PM	0
4/1/2025	7:15:00 PM	0
4/1/2025	7:30:00 PM	0
4/1/2025	7:45:00 PM	0
4/1/2025	8:00:00 PM	0
4/1/2025	8:15:00 PM	0
4/1/2025	8:30:00 PM	0
4/1/2025	8:45:00 PM	0
4/1/2025	9:00:00 PM	0
4/1/2025	9:15:00 PM	0
4/1/2025	9:30:00 PM	0
4/1/2025	9:45:00 PM	0
4/1/2025	10:00:00 PM	0
4/1/2025	10:15:00 PM	0
4/1/2025	10:30:00 PM	0
4/1/2025	10:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/1/2025	11:00:00 PM	0
4/1/2025	11:15:00 PM	0
4/1/2025	11:30:00 PM	0
4/1/2025	11:45:00 PM	0
4/2/2025	12:00:00 AM	0
4/2/2025	12:15:00 AM	0
4/2/2025	12:30:00 AM	0
4/2/2025	12:45:00 AM	0
4/2/2025	1:00:00 AM	0
4/2/2025	1:15:00 AM	0
4/2/2025	1:30:00 AM	0
4/2/2025	1:45:00 AM	0
4/2/2025	2:00:00 AM	0
4/2/2025	2:15:00 AM	0
4/2/2025	2:30:00 AM	0
4/2/2025	2:45:00 AM	0
4/2/2025	3:00:00 AM	0
4/2/2025	3:15:00 AM	0
4/2/2025	3:30:00 AM	0
4/2/2025	3:45:00 AM	0
4/2/2025	4:00:00 AM	0
4/2/2025	4:15:00 AM	0
4/2/2025	4:30:00 AM	0
4/2/2025	4:45:00 AM	0
4/2/2025	5:00:00 AM	0
4/2/2025	5:15:00 AM	0
4/2/2025	5:30:00 AM	0
4/2/2025	5:45:00 AM	0
4/2/2025	6:00:00 AM	0
4/2/2025	6:15:00 AM	0
4/2/2025	6:30:00 AM	0
4/2/2025	6:45:00 AM	0
4/2/2025	7:00:00 AM	0
4/2/2025	7:15:00 AM	0
4/2/2025	7:30:00 AM	0
4/2/2025	7:45:00 AM	0
4/2/2025	8:00:00 AM	0
4/2/2025	8:15:00 AM	0
4/2/2025	8:30:00 AM	0
4/2/2025	8:45:00 AM	0
4/2/2025	9:00:00 AM	0
4/2/2025	9:15:00 AM	0
4/2/2025	9:30:00 AM	0
4/2/2025	9:45:00 AM	0
4/2/2025	10:00:00 AM	0
4/2/2025	10:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/2/2025	10:30:00 AM	0
4/2/2025	10:45:00 AM	0
4/2/2025	11:00:00 AM	0
4/2/2025	11:15:00 AM	0
4/2/2025	11:30:00 AM	0
4/2/2025	11:45:00 AM	0
4/2/2025	12:00:00 PM	0
4/2/2025	12:15:00 PM	0
4/2/2025	12:30:00 PM	0
4/2/2025	12:45:00 PM	0
4/2/2025	1:00:00 PM	0
4/2/2025	1:15:00 PM	0
4/2/2025	1:30:00 PM	0
4/2/2025	1:45:00 PM	0
4/2/2025	2:00:00 PM	0
4/2/2025	2:15:00 PM	0
4/2/2025	2:30:00 PM	0
4/2/2025	2:45:00 PM	0
4/2/2025	3:00:00 PM	0
4/2/2025	3:15:00 PM	0
4/2/2025	3:30:00 PM	0
4/2/2025	3:45:00 PM	0
4/2/2025	4:00:00 PM	0
4/2/2025	4:15:00 PM	0
4/2/2025	4:30:00 PM	0
4/2/2025	4:45:00 PM	0
4/2/2025	5:00:00 PM	0
4/2/2025	5:15:00 PM	0
4/2/2025	5:30:00 PM	0
4/2/2025	5:45:00 PM	0
4/2/2025	6:00:00 PM	0
4/2/2025	6:15:00 PM	0
4/2/2025	6:30:00 PM	0
4/2/2025	6:45:00 PM	0
4/2/2025	7:00:00 PM	0
4/2/2025	7:15:00 PM	0
4/2/2025	7:30:00 PM	0
4/2/2025	7:45:00 PM	0
4/2/2025	8:00:00 PM	0
4/2/2025	8:15:00 PM	0
4/2/2025	8:30:00 PM	0
4/2/2025	8:45:00 PM	0
4/2/2025	9:00:00 PM	0
4/2/2025	9:15:00 PM	0
4/2/2025	9:30:00 PM	0
4/2/2025	9:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/2/2025	10:00:00 PM	0
4/2/2025	10:15:00 PM	0
4/2/2025	10:30:00 PM	0
4/2/2025	10:45:00 PM	0
4/2/2025	11:00:00 PM	0
4/2/2025	11:15:00 PM	0
4/2/2025	11:30:00 PM	0
4/2/2025	11:45:00 PM	0
4/3/2025	12:00:00 AM	0
4/3/2025	12:15:00 AM	0
4/3/2025	12:30:00 AM	0
4/3/2025	12:45:00 AM	0
4/3/2025	1:00:00 AM	0
4/3/2025	1:15:00 AM	0
4/3/2025	1:30:00 AM	0
4/3/2025	1:45:00 AM	0
4/3/2025	2:00:00 AM	0
4/3/2025	2:15:00 AM	0
4/3/2025	2:30:00 AM	0
4/3/2025	2:45:00 AM	0
4/3/2025	3:00:00 AM	0
4/3/2025	3:15:00 AM	0
4/3/2025	3:30:00 AM	0
4/3/2025	3:45:00 AM	0
4/3/2025	4:00:00 AM	0
4/3/2025	4:15:00 AM	0
4/3/2025	4:30:00 AM	0
4/3/2025	4:45:00 AM	0
4/3/2025	5:00:00 AM	0
4/3/2025	5:15:00 AM	0
4/3/2025	5:30:00 AM	0
4/3/2025	5:45:00 AM	0
4/3/2025	6:00:00 AM	0
4/3/2025	6:15:00 AM	0
4/3/2025	6:30:00 AM	0
4/3/2025	6:45:00 AM	0
4/3/2025	7:00:00 AM	0
4/3/2025	7:15:00 AM	0
4/3/2025	7:30:00 AM	0
4/3/2025	7:45:00 AM	0
4/3/2025	8:00:00 AM	0
4/3/2025	8:15:00 AM	0
4/3/2025	8:30:00 AM	0
4/3/2025	8:45:00 AM	0
4/3/2025	9:00:00 AM	0
4/3/2025	9:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/3/2025	9:30:00 AM	0
4/3/2025	9:45:00 AM	0
4/3/2025	10:00:00 AM	0
4/3/2025	10:15:00 AM	0
4/3/2025	10:30:00 AM	0
4/3/2025	10:45:00 AM	0
4/3/2025	11:00:00 AM	0
4/3/2025	11:15:00 AM	0
4/3/2025	11:30:00 AM	0
4/3/2025	11:45:00 AM	0
4/3/2025	12:00:00 PM	0
4/3/2025	12:15:00 PM	0
4/3/2025	12:30:00 PM	0
4/3/2025	12:45:00 PM	0
4/3/2025	1:00:00 PM	0
4/3/2025	1:15:00 PM	0
4/3/2025	1:30:00 PM	0
4/3/2025	1:45:00 PM	0
4/3/2025	2:00:00 PM	0
4/3/2025	2:15:00 PM	0
4/3/2025	2:30:00 PM	0
4/3/2025	2:45:00 PM	0
4/3/2025	3:00:00 PM	0
4/3/2025	3:15:00 PM	0
4/3/2025	3:30:00 PM	0
4/3/2025	3:45:00 PM	0
4/3/2025	4:00:00 PM	0
4/3/2025	4:15:00 PM	0
4/3/2025	4:30:00 PM	0
4/3/2025	4:45:00 PM	0
4/3/2025	5:00:00 PM	0
4/3/2025	5:15:00 PM	0
4/3/2025	5:30:00 PM	0
4/3/2025	5:45:00 PM	0
4/3/2025	6:00:00 PM	0
4/3/2025	6:15:00 PM	0
4/3/2025	6:30:00 PM	0
4/3/2025	6:45:00 PM	0
4/3/2025	7:00:00 PM	0
4/3/2025	7:15:00 PM	0
4/3/2025	7:30:00 PM	0
4/3/2025	7:45:00 PM	0
4/3/2025	8:00:00 PM	0
4/3/2025	8:15:00 PM	0
4/3/2025	8:30:00 PM	0
4/3/2025	8:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/3/2025	9:00:00 PM	0
4/3/2025	9:15:00 PM	0
4/3/2025	9:30:00 PM	0
4/3/2025	9:45:00 PM	0
4/3/2025	10:00:00 PM	0
4/3/2025	10:15:00 PM	0
4/3/2025	10:30:00 PM	0
4/3/2025	10:45:00 PM	0
4/3/2025	11:00:00 PM	0
4/3/2025	11:15:00 PM	0
4/3/2025	11:30:00 PM	0
4/3/2025	11:45:00 PM	0
4/4/2025	12:00:00 AM	0
4/4/2025	12:15:00 AM	0
4/4/2025	12:30:00 AM	0
4/4/2025	12:45:00 AM	0
4/4/2025	1:00:00 AM	0
4/4/2025	1:15:00 AM	0
4/4/2025	1:30:00 AM	0
4/4/2025	1:45:00 AM	0
4/4/2025	2:00:00 AM	0
4/4/2025	2:15:00 AM	0
4/4/2025	2:30:00 AM	0
4/4/2025	2:45:00 AM	0
4/4/2025	3:00:00 AM	0
4/4/2025	3:15:00 AM	0
4/4/2025	3:30:00 AM	0
4/4/2025	3:45:00 AM	0
4/4/2025	4:00:00 AM	0
4/4/2025	4:15:00 AM	0
4/4/2025	4:30:00 AM	0
4/4/2025	4:45:00 AM	0
4/4/2025	5:00:00 AM	0
4/4/2025	5:15:00 AM	0
4/4/2025	5:30:00 AM	0
4/4/2025	5:45:00 AM	0
4/4/2025	6:00:00 AM	0
4/4/2025	6:15:00 AM	0
4/4/2025	6:30:00 AM	0
4/4/2025	6:45:00 AM	0
4/4/2025	7:00:00 AM	0
4/4/2025	7:15:00 AM	0
4/4/2025	7:30:00 AM	0
4/4/2025	7:45:00 AM	0
4/4/2025	8:00:00 AM	0
4/4/2025	8:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/4/2025	8:30:00 AM	0
4/4/2025	8:45:00 AM	0
4/4/2025	9:00:00 AM	0
4/4/2025	9:15:00 AM	0
4/4/2025	9:30:00 AM	0
4/4/2025	9:45:00 AM	0
4/4/2025	10:00:00 AM	0
4/4/2025	10:15:00 AM	0
4/4/2025	10:30:00 AM	0
4/4/2025	10:45:00 AM	0
4/4/2025	11:00:00 AM	0
4/4/2025	11:15:00 AM	0
4/4/2025	11:30:00 AM	0
4/4/2025	11:45:00 AM	0
4/4/2025	12:00:00 PM	0
4/4/2025	12:15:00 PM	0
4/4/2025	12:30:00 PM	0
4/4/2025	12:45:00 PM	0
4/4/2025	1:00:00 PM	0
4/4/2025	1:15:00 PM	0
4/4/2025	1:30:00 PM	0
4/4/2025	1:45:00 PM	0
4/4/2025	2:00:00 PM	0
4/4/2025	2:15:00 PM	0
4/4/2025	2:30:00 PM	0
4/4/2025	2:45:00 PM	0
4/4/2025	3:00:00 PM	0
4/4/2025	3:15:00 PM	0
4/4/2025	3:30:00 PM	0
4/4/2025	3:45:00 PM	0
4/4/2025	4:00:00 PM	0
4/4/2025	4:15:00 PM	0
4/4/2025	4:30:00 PM	0
4/4/2025	4:45:00 PM	0
4/4/2025	5:00:00 PM	0
4/4/2025	5:15:00 PM	0
4/4/2025	5:30:00 PM	0
4/4/2025	5:45:00 PM	0
4/4/2025	6:00:00 PM	0
4/4/2025	6:15:00 PM	0
4/4/2025	6:30:00 PM	0
4/4/2025	6:45:00 PM	0
4/4/2025	7:00:00 PM	0
4/4/2025	7:15:00 PM	0
4/4/2025	7:30:00 PM	0
4/4/2025	7:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/4/2025	8:00:00 PM	0
4/4/2025	8:15:00 PM	0
4/4/2025	8:30:00 PM	0
4/4/2025	8:45:00 PM	0
4/4/2025	9:00:00 PM	0
4/4/2025	9:15:00 PM	0
4/4/2025	9:30:00 PM	0
4/4/2025	9:45:00 PM	0
4/4/2025	10:00:00 PM	0
4/4/2025	10:15:00 PM	0
4/4/2025	10:30:00 PM	0
4/4/2025	10:45:00 PM	0
4/4/2025	11:00:00 PM	0
4/4/2025	11:15:00 PM	0
4/4/2025	11:30:00 PM	0
4/4/2025	11:45:00 PM	0
4/5/2025	12:00:00 AM	0
4/5/2025	12:15:00 AM	0
4/5/2025	12:30:00 AM	0
4/5/2025	12:45:00 AM	0
4/5/2025	1:00:00 AM	0
4/5/2025	1:15:00 AM	0
4/5/2025	1:30:00 AM	0
4/5/2025	1:45:00 AM	0
4/5/2025	2:00:00 AM	0
4/5/2025	2:15:00 AM	0
4/5/2025	2:30:00 AM	0
4/5/2025	2:45:00 AM	0
4/5/2025	3:00:00 AM	0
4/5/2025	3:15:00 AM	0
4/5/2025	3:30:00 AM	0
4/5/2025	3:45:00 AM	0
4/5/2025	4:00:00 AM	0
4/5/2025	4:15:00 AM	0
4/5/2025	4:30:00 AM	0
4/5/2025	4:45:00 AM	0
4/5/2025	5:00:00 AM	0
4/5/2025	5:15:00 AM	0
4/5/2025	5:30:00 AM	0
4/5/2025	5:45:00 AM	0
4/5/2025	6:00:00 AM	0
4/5/2025	6:15:00 AM	0
4/5/2025	6:30:00 AM	0
4/5/2025	6:45:00 AM	0
4/5/2025	7:00:00 AM	0
4/5/2025	7:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/5/2025	7:30:00 AM	0
4/5/2025	7:45:00 AM	0
4/5/2025	8:00:00 AM	0
4/5/2025	8:15:00 AM	0
4/5/2025	8:30:00 AM	0
4/5/2025	8:45:00 AM	0
4/5/2025	9:00:00 AM	0
4/5/2025	9:15:00 AM	0
4/5/2025	9:30:00 AM	0
4/5/2025	9:45:00 AM	0
4/5/2025	10:00:00 AM	0
4/5/2025	10:15:00 AM	0
4/5/2025	10:30:00 AM	0
4/5/2025	10:45:00 AM	0
4/5/2025	11:00:00 AM	0
4/5/2025	11:15:00 AM	0
4/5/2025	11:30:00 AM	0
4/5/2025	11:45:00 AM	0
4/5/2025	12:00:00 PM	0
4/5/2025	12:15:00 PM	0
4/5/2025	12:30:00 PM	0
4/5/2025	12:45:00 PM	0
4/5/2025	1:00:00 PM	0
4/5/2025	1:15:00 PM	0
4/5/2025	1:30:00 PM	0
4/5/2025	1:45:00 PM	0
4/5/2025	2:00:00 PM	0
4/5/2025	2:15:00 PM	0
4/5/2025	2:30:00 PM	0
4/5/2025	2:45:00 PM	0
4/5/2025	3:00:00 PM	0
4/5/2025	3:15:00 PM	0
4/5/2025	3:30:00 PM	0
4/5/2025	3:45:00 PM	0
4/5/2025	4:00:00 PM	0
4/5/2025	4:15:00 PM	0
4/5/2025	4:30:00 PM	0
4/5/2025	4:45:00 PM	0
4/5/2025	5:00:00 PM	0
4/5/2025	5:15:00 PM	0
4/5/2025	5:30:00 PM	0
4/5/2025	5:45:00 PM	0
4/5/2025	6:00:00 PM	0
4/5/2025	6:15:00 PM	0
4/5/2025	6:30:00 PM	0
4/5/2025	6:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/5/2025	7:00:00 PM	0
4/5/2025	7:15:00 PM	0
4/5/2025	7:30:00 PM	0
4/5/2025	7:45:00 PM	0
4/5/2025	8:00:00 PM	0
4/5/2025	8:15:00 PM	0
4/5/2025	8:30:00 PM	0
4/5/2025	8:45:00 PM	0
4/5/2025	9:00:00 PM	0
4/5/2025	9:15:00 PM	0
4/5/2025	9:30:00 PM	0
4/5/2025	9:45:00 PM	0
4/5/2025	10:00:00 PM	0
4/5/2025	10:15:00 PM	0
4/5/2025	10:30:00 PM	0
4/5/2025	10:45:00 PM	0
4/5/2025	11:00:00 PM	0
4/5/2025	11:15:00 PM	0
4/5/2025	11:30:00 PM	0
4/5/2025	11:45:00 PM	0
4/6/2025	12:00:00 AM	0
4/6/2025	12:15:00 AM	0
4/6/2025	12:30:00 AM	0
4/6/2025	12:45:00 AM	0
4/6/2025	1:00:00 AM	0
4/6/2025	1:15:00 AM	0
4/6/2025	1:30:00 AM	0
4/6/2025	1:45:00 AM	0
4/6/2025	2:00:00 AM	0
4/6/2025	2:15:00 AM	0
4/6/2025	2:30:00 AM	0
4/6/2025	2:45:00 AM	0
4/6/2025	3:00:00 AM	0
4/6/2025	3:15:00 AM	0
4/6/2025	3:30:00 AM	0
4/6/2025	3:45:00 AM	0
4/6/2025	4:00:00 AM	0
4/6/2025	4:15:00 AM	0
4/6/2025	4:30:00 AM	0
4/6/2025	4:45:00 AM	0
4/6/2025	5:00:00 AM	0
4/6/2025	5:15:00 AM	0
4/6/2025	5:30:00 AM	0
4/6/2025	5:45:00 AM	0
4/6/2025	6:00:00 AM	0
4/6/2025	6:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/6/2025	6:30:00 AM	0
4/6/2025	6:45:00 AM	0
4/6/2025	7:00:00 AM	0
4/6/2025	7:15:00 AM	0
4/6/2025	7:30:00 AM	0
4/6/2025	7:45:00 AM	0
4/6/2025	8:00:00 AM	0
4/6/2025	8:15:00 AM	0
4/6/2025	8:30:00 AM	0
4/6/2025	8:45:00 AM	0
4/6/2025	9:00:00 AM	0
4/6/2025	9:15:00 AM	0
4/6/2025	9:30:00 AM	0
4/6/2025	9:45:00 AM	0
4/6/2025	10:00:00 AM	0
4/6/2025	10:15:00 AM	0
4/6/2025	10:30:00 AM	0
4/6/2025	10:45:00 AM	0
4/6/2025	11:00:00 AM	0
4/6/2025	11:15:00 AM	0
4/6/2025	11:30:00 AM	0
4/6/2025	11:45:00 AM	0
4/6/2025	12:00:00 PM	0
4/6/2025	12:15:00 PM	0
4/6/2025	12:30:00 PM	0
4/6/2025	12:45:00 PM	0
4/6/2025	1:00:00 PM	0
4/6/2025	1:15:00 PM	0
4/6/2025	1:30:00 PM	0
4/6/2025	1:45:00 PM	0
4/6/2025	2:00:00 PM	0
4/6/2025	2:15:00 PM	0
4/6/2025	2:30:00 PM	0
4/6/2025	2:45:00 PM	0
4/6/2025	3:00:00 PM	0
4/6/2025	3:15:00 PM	0
4/6/2025	3:30:00 PM	0
4/6/2025	3:45:00 PM	0
4/6/2025	4:00:00 PM	0
4/6/2025	4:15:00 PM	0
4/6/2025	4:30:00 PM	0
4/6/2025	4:45:00 PM	0
4/6/2025	5:00:00 PM	0
4/6/2025	5:15:00 PM	0
4/6/2025	5:30:00 PM	0
4/6/2025	5:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/6/2025	6:00:00 PM	0
4/6/2025	6:15:00 PM	0
4/6/2025	6:30:00 PM	0
4/6/2025	6:45:00 PM	0
4/6/2025	7:00:00 PM	0
4/6/2025	7:15:00 PM	0
4/6/2025	7:30:00 PM	0
4/6/2025	7:45:00 PM	0
4/6/2025	8:00:00 PM	0
4/6/2025	8:15:00 PM	0
4/6/2025	8:30:00 PM	0
4/6/2025	8:45:00 PM	0
4/6/2025	9:00:00 PM	0
4/6/2025	9:15:00 PM	0
4/6/2025	9:30:00 PM	0
4/6/2025	9:45:00 PM	0
4/6/2025	10:00:00 PM	0
4/6/2025	10:15:00 PM	0
4/6/2025	10:30:00 PM	0
4/6/2025	10:45:00 PM	0
4/6/2025	11:00:00 PM	0
4/6/2025	11:15:00 PM	0
4/6/2025	11:30:00 PM	0
4/6/2025	11:45:00 PM	0
4/7/2025	12:00:00 AM	0
4/7/2025	12:15:00 AM	0
4/7/2025	12:30:00 AM	0
4/7/2025	12:45:00 AM	0
4/7/2025	1:00:00 AM	0
4/7/2025	1:15:00 AM	0
4/7/2025	1:30:00 AM	0
4/7/2025	1:45:00 AM	0
4/7/2025	2:00:00 AM	0
4/7/2025	2:15:00 AM	0
4/7/2025	2:30:00 AM	0
4/7/2025	2:45:00 AM	0
4/7/2025	3:00:00 AM	0
4/7/2025	3:15:00 AM	0
4/7/2025	3:30:00 AM	0
4/7/2025	3:45:00 AM	0
4/7/2025	4:00:00 AM	0
4/7/2025	4:15:00 AM	0
4/7/2025	4:30:00 AM	0
4/7/2025	4:45:00 AM	0
4/7/2025	5:00:00 AM	0
4/7/2025	5:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/7/2025	5:30:00 AM	0
4/7/2025	5:45:00 AM	0
4/7/2025	6:00:00 AM	0
4/7/2025	6:15:00 AM	0
4/7/2025	6:30:00 AM	0
4/7/2025	6:45:00 AM	0
4/7/2025	7:00:00 AM	0
4/7/2025	7:15:00 AM	0
4/7/2025	7:30:00 AM	0
4/7/2025	7:45:00 AM	0
4/7/2025	8:00:00 AM	0
4/7/2025	8:15:00 AM	0
4/7/2025	8:30:00 AM	0
4/7/2025	8:45:00 AM	0
4/7/2025	9:00:00 AM	0
4/7/2025	9:15:00 AM	0
4/7/2025	9:30:00 AM	0
4/7/2025	9:45:00 AM	0
4/7/2025	10:00:00 AM	0
4/7/2025	10:15:00 AM	0
4/7/2025	10:30:00 AM	0
4/7/2025	10:45:00 AM	0
4/7/2025	11:00:00 AM	0
4/7/2025	11:15:00 AM	0
4/7/2025	11:30:00 AM	0
4/7/2025	11:45:00 AM	0
4/7/2025	12:00:00 PM	0
4/7/2025	12:15:00 PM	0
4/7/2025	12:30:00 PM	0
4/7/2025	12:45:00 PM	0
4/7/2025	1:00:00 PM	0
4/7/2025	1:15:00 PM	0
4/7/2025	1:30:00 PM	0
4/7/2025	1:45:00 PM	0
4/7/2025	2:00:00 PM	0
4/7/2025	2:15:00 PM	0
4/7/2025	2:30:00 PM	0
4/7/2025	2:45:00 PM	0
4/7/2025	3:00:00 PM	0
4/7/2025	3:15:00 PM	0
4/7/2025	3:30:00 PM	0
4/7/2025	3:45:00 PM	0
4/7/2025	4:00:00 PM	0
4/7/2025	4:15:00 PM	0
4/7/2025	4:30:00 PM	0
4/7/2025	4:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/7/2025	5:00:00 PM	0
4/7/2025	5:15:00 PM	0
4/7/2025	5:30:00 PM	0
4/7/2025	5:45:00 PM	0
4/7/2025	6:00:00 PM	0
4/7/2025	6:15:00 PM	0
4/7/2025	6:30:00 PM	0
4/7/2025	6:45:00 PM	0
4/7/2025	7:00:00 PM	0
4/7/2025	7:15:00 PM	0
4/7/2025	7:30:00 PM	0
4/7/2025	7:45:00 PM	0
4/7/2025	8:00:00 PM	0
4/7/2025	8:15:00 PM	0
4/7/2025	8:30:00 PM	0
4/7/2025	8:45:00 PM	0
4/7/2025	9:00:00 PM	0
4/7/2025	9:15:00 PM	0
4/7/2025	9:30:00 PM	0
4/7/2025	9:45:00 PM	0
4/7/2025	10:00:00 PM	0
4/7/2025	10:15:00 PM	0
4/7/2025	10:30:00 PM	0
4/7/2025	10:45:00 PM	0
4/7/2025	11:00:00 PM	0
4/7/2025	11:15:00 PM	0
4/7/2025	11:30:00 PM	0
4/7/2025	11:45:00 PM	0
4/8/2025	12:00:00 AM	0
4/8/2025	12:15:00 AM	0
4/8/2025	12:30:00 AM	0
4/8/2025	12:45:00 AM	0
4/8/2025	1:00:00 AM	0
4/8/2025	1:15:00 AM	0
4/8/2025	1:30:00 AM	0
4/8/2025	1:45:00 AM	0
4/8/2025	2:00:00 AM	0
4/8/2025	2:15:00 AM	0
4/8/2025	2:30:00 AM	0
4/8/2025	2:45:00 AM	0
4/8/2025	3:00:00 AM	0
4/8/2025	3:15:00 AM	0
4/8/2025	3:30:00 AM	0
4/8/2025	3:45:00 AM	0
4/8/2025	4:00:00 AM	0
4/8/2025	4:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/8/2025	4:30:00 AM	0
4/8/2025	4:45:00 AM	0
4/8/2025	5:00:00 AM	0
4/8/2025	5:15:00 AM	0
4/8/2025	5:30:00 AM	0
4/8/2025	5:45:00 AM	0
4/8/2025	6:00:00 AM	0
4/8/2025	6:15:00 AM	0
4/8/2025	6:30:00 AM	0
4/8/2025	6:45:00 AM	0
4/8/2025	7:00:00 AM	0
4/8/2025	7:15:00 AM	0
4/8/2025	7:30:00 AM	0
4/8/2025	7:45:00 AM	0
4/8/2025	8:00:00 AM	0
4/8/2025	8:15:00 AM	0
4/8/2025	8:30:00 AM	0
4/8/2025	8:45:00 AM	0
4/8/2025	9:00:00 AM	0
4/8/2025	9:15:00 AM	0
4/8/2025	9:30:00 AM	0
4/8/2025	9:45:00 AM	0
4/8/2025	10:00:00 AM	0
4/8/2025	10:15:00 AM	0
4/8/2025	10:30:00 AM	0
4/8/2025	10:45:00 AM	0
4/8/2025	11:00:00 AM	0
4/8/2025	11:15:00 AM	0
4/8/2025	11:30:00 AM	0
4/8/2025	11:45:00 AM	0
4/8/2025	12:00:00 PM	0
4/8/2025	12:15:00 PM	0
4/8/2025	12:30:00 PM	0
4/8/2025	12:45:00 PM	0
4/8/2025	1:00:00 PM	0
4/8/2025	1:15:00 PM	0
4/8/2025	1:30:00 PM	0
4/8/2025	1:45:00 PM	0
4/8/2025	2:00:00 PM	0
4/8/2025	2:15:00 PM	0
4/8/2025	2:30:00 PM	0
4/8/2025	2:45:00 PM	0
4/8/2025	3:00:00 PM	0
4/8/2025	3:15:00 PM	0
4/8/2025	3:30:00 PM	0
4/8/2025	3:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/8/2025	4:00:00 PM	0
4/8/2025	4:15:00 PM	0
4/8/2025	4:30:00 PM	0
4/8/2025	4:45:00 PM	0
4/8/2025	5:00:00 PM	0
4/8/2025	5:15:00 PM	0
4/8/2025	5:30:00 PM	0
4/8/2025	5:45:00 PM	0
4/8/2025	6:00:00 PM	0
4/8/2025	6:15:00 PM	0
4/8/2025	6:30:00 PM	0
4/8/2025	6:45:00 PM	0
4/8/2025	7:00:00 PM	0
4/8/2025	7:15:00 PM	0
4/8/2025	7:30:00 PM	0
4/8/2025	7:45:00 PM	0
4/8/2025	8:00:00 PM	0
4/8/2025	8:15:00 PM	0
4/8/2025	8:30:00 PM	0
4/8/2025	8:45:00 PM	0
4/8/2025	9:00:00 PM	0
4/8/2025	9:15:00 PM	0
4/8/2025	9:30:00 PM	0
4/8/2025	9:45:00 PM	0
4/8/2025	10:00:00 PM	0
4/8/2025	10:15:00 PM	0
4/8/2025	10:30:00 PM	0
4/8/2025	10:45:00 PM	0
4/8/2025	11:00:00 PM	0
4/8/2025	11:15:00 PM	0
4/8/2025	11:30:00 PM	0
4/8/2025	11:45:00 PM	0
4/9/2025	12:00:00 AM	0
4/9/2025	12:15:00 AM	0
4/9/2025	12:30:00 AM	0
4/9/2025	12:45:00 AM	0
4/9/2025	1:00:00 AM	0
4/9/2025	1:15:00 AM	0
4/9/2025	1:30:00 AM	0
4/9/2025	1:45:00 AM	0
4/9/2025	2:00:00 AM	0
4/9/2025	2:15:00 AM	0
4/9/2025	2:30:00 AM	0
4/9/2025	2:45:00 AM	0
4/9/2025	3:00:00 AM	0
4/9/2025	3:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/9/2025	3:30:00 AM	0
4/9/2025	3:45:00 AM	0
4/9/2025	4:00:00 AM	0
4/9/2025	4:15:00 AM	0
4/9/2025	4:30:00 AM	0
4/9/2025	4:45:00 AM	0
4/9/2025	5:00:00 AM	0
4/9/2025	5:15:00 AM	0
4/9/2025	5:30:00 AM	0
4/9/2025	5:45:00 AM	0
4/9/2025	6:00:00 AM	0
4/9/2025	6:15:00 AM	0
4/9/2025	6:30:00 AM	0
4/9/2025	6:45:00 AM	0
4/9/2025	7:00:00 AM	0
4/9/2025	7:15:00 AM	0
4/9/2025	7:30:00 AM	0
4/9/2025	7:45:00 AM	0
4/9/2025	8:00:00 AM	0
4/9/2025	8:15:00 AM	0
4/9/2025	8:30:00 AM	0
4/9/2025	8:45:00 AM	0
4/9/2025	9:00:00 AM	0
4/9/2025	9:15:00 AM	0
4/9/2025	9:30:00 AM	0
4/9/2025	9:45:00 AM	0
4/9/2025	10:00:00 AM	0
4/9/2025	10:15:00 AM	0
4/9/2025	10:30:00 AM	0
4/9/2025	10:45:00 AM	0
4/9/2025	11:00:00 AM	0
4/9/2025	11:15:00 AM	0
4/9/2025	11:30:00 AM	0
4/9/2025	11:45:00 AM	0
4/9/2025	12:00:00 PM	0
4/9/2025	12:15:00 PM	0
4/9/2025	12:30:00 PM	0
4/9/2025	12:45:00 PM	0
4/9/2025	1:00:00 PM	0
4/9/2025	1:15:00 PM	0
4/9/2025	1:30:00 PM	0
4/9/2025	1:45:00 PM	0
4/9/2025	2:00:00 PM	0
4/9/2025	2:15:00 PM	0
4/9/2025	2:30:00 PM	0
4/9/2025	2:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/9/2025	3:00:00 PM	0
4/9/2025	3:15:00 PM	0
4/9/2025	3:30:00 PM	0
4/9/2025	3:45:00 PM	0
4/9/2025	4:00:00 PM	0
4/9/2025	4:15:00 PM	0
4/9/2025	4:30:00 PM	0
4/9/2025	4:45:00 PM	0
4/9/2025	5:00:00 PM	0
4/9/2025	5:15:00 PM	0
4/9/2025	5:30:00 PM	0
4/9/2025	5:45:00 PM	0
4/9/2025	6:00:00 PM	0
4/9/2025	6:15:00 PM	0
4/9/2025	6:30:00 PM	0
4/9/2025	6:45:00 PM	0
4/9/2025	7:00:00 PM	0
4/9/2025	7:15:00 PM	0
4/9/2025	7:30:00 PM	0
4/9/2025	7:45:00 PM	0
4/9/2025	8:00:00 PM	0
4/9/2025	8:15:00 PM	0
4/9/2025	8:30:00 PM	0
4/9/2025	8:45:00 PM	0
4/9/2025	9:00:00 PM	0
4/9/2025	9:15:00 PM	0
4/9/2025	9:30:00 PM	0
4/9/2025	9:45:00 PM	0
4/9/2025	10:00:00 PM	0
4/9/2025	10:15:00 PM	0
4/9/2025	10:30:00 PM	0
4/9/2025	10:45:00 PM	0
4/9/2025	11:00:00 PM	0
4/9/2025	11:15:00 PM	0
4/9/2025	11:30:00 PM	0
4/9/2025	11:45:00 PM	0
4/10/2025	12:00:00 AM	0
4/10/2025	12:15:00 AM	0
4/10/2025	12:30:00 AM	0
4/10/2025	12:45:00 AM	0
4/10/2025	1:00:00 AM	0
4/10/2025	1:15:00 AM	0
4/10/2025	1:30:00 AM	0
4/10/2025	1:45:00 AM	0
4/10/2025	2:00:00 AM	0
4/10/2025	2:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/10/2025	2:30:00 AM	0
4/10/2025	2:45:00 AM	0
4/10/2025	3:00:00 AM	0
4/10/2025	3:15:00 AM	0
4/10/2025	3:30:00 AM	0
4/10/2025	3:45:00 AM	0
4/10/2025	4:00:00 AM	0
4/10/2025	4:15:00 AM	0
4/10/2025	4:30:00 AM	0
4/10/2025	4:45:00 AM	0
4/10/2025	5:00:00 AM	0
4/10/2025	5:15:00 AM	0
4/10/2025	5:30:00 AM	0
4/10/2025	5:45:00 AM	0
4/10/2025	6:00:00 AM	0
4/10/2025	6:15:00 AM	0
4/10/2025	6:30:00 AM	0
4/10/2025	6:45:00 AM	0
4/10/2025	7:00:00 AM	0
4/10/2025	7:15:00 AM	0
4/10/2025	7:30:00 AM	0
4/10/2025	7:45:00 AM	0
4/10/2025	8:00:00 AM	0
4/10/2025	8:15:00 AM	0
4/10/2025	8:30:00 AM	0
4/10/2025	8:45:00 AM	0
4/10/2025	9:00:00 AM	0
4/10/2025	9:15:00 AM	0
4/10/2025	9:30:00 AM	0
4/10/2025	9:45:00 AM	0
4/10/2025	10:00:00 AM	0
4/10/2025	10:15:00 AM	0
4/10/2025	10:30:00 AM	0
4/10/2025	10:45:00 AM	0
4/10/2025	11:00:00 AM	0
4/10/2025	11:15:00 AM	0
4/10/2025	11:30:00 AM	0
4/10/2025	11:45:00 AM	0
4/10/2025	12:00:00 PM	0
4/10/2025	12:15:00 PM	0
4/10/2025	12:30:00 PM	0
4/10/2025	12:45:00 PM	0
4/10/2025	1:00:00 PM	0
4/10/2025	1:15:00 PM	0
4/10/2025	1:30:00 PM	0
4/10/2025	1:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/10/2025	2:00:00 PM	0
4/10/2025	2:15:00 PM	0
4/10/2025	2:30:00 PM	0
4/10/2025	2:45:00 PM	0
4/10/2025	3:00:00 PM	0
4/10/2025	3:15:00 PM	0
4/10/2025	3:30:00 PM	0
4/10/2025	3:45:00 PM	0
4/10/2025	4:00:00 PM	0
4/10/2025	4:15:00 PM	0
4/10/2025	4:30:00 PM	0
4/10/2025	4:45:00 PM	0
4/10/2025	5:00:00 PM	0
4/10/2025	5:15:00 PM	0
4/10/2025	5:30:00 PM	0
4/10/2025	5:45:00 PM	0
4/10/2025	6:00:00 PM	0
4/10/2025	6:15:00 PM	0
4/10/2025	6:30:00 PM	0
4/10/2025	6:45:00 PM	0
4/10/2025	7:00:00 PM	0
4/10/2025	7:15:00 PM	0
4/10/2025	7:30:00 PM	0
4/10/2025	7:45:00 PM	0
4/10/2025	8:00:00 PM	0
4/10/2025	8:15:00 PM	0
4/10/2025	8:30:00 PM	0
4/10/2025	8:45:00 PM	0
4/10/2025	9:00:00 PM	0
4/10/2025	9:15:00 PM	0
4/10/2025	9:30:00 PM	0
4/10/2025	9:45:00 PM	0
4/10/2025	10:00:00 PM	0
4/10/2025	10:15:00 PM	0
4/10/2025	10:30:00 PM	0
4/10/2025	10:45:00 PM	0
4/10/2025	11:00:00 PM	0
4/10/2025	11:15:00 PM	0
4/10/2025	11:30:00 PM	0
4/10/2025	11:45:00 PM	0
4/11/2025	12:00:00 AM	0
4/11/2025	12:15:00 AM	0
4/11/2025	12:30:00 AM	0
4/11/2025	12:45:00 AM	0
4/11/2025	1:00:00 AM	0
4/11/2025	1:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/11/2025	1:30:00 AM	0
4/11/2025	1:45:00 AM	0
4/11/2025	2:00:00 AM	0
4/11/2025	2:15:00 AM	0
4/11/2025	2:30:00 AM	0
4/11/2025	2:45:00 AM	0
4/11/2025	3:00:00 AM	0
4/11/2025	3:15:00 AM	0
4/11/2025	3:30:00 AM	0
4/11/2025	3:45:00 AM	0
4/11/2025	4:00:00 AM	0
4/11/2025	4:15:00 AM	0
4/11/2025	4:30:00 AM	0
4/11/2025	4:45:00 AM	0
4/11/2025	5:00:00 AM	0
4/11/2025	5:15:00 AM	0
4/11/2025	5:30:00 AM	0
4/11/2025	5:45:00 AM	0
4/11/2025	6:00:00 AM	0
4/11/2025	6:15:00 AM	0
4/11/2025	6:30:00 AM	0
4/11/2025	6:45:00 AM	0
4/11/2025	7:00:00 AM	0
4/11/2025	7:15:00 AM	0
4/11/2025	7:30:00 AM	0
4/11/2025	7:45:00 AM	0
4/11/2025	8:00:00 AM	0
4/11/2025	8:15:00 AM	0
4/11/2025	8:30:00 AM	0
4/11/2025	8:45:00 AM	0
4/11/2025	9:00:00 AM	0
4/11/2025	9:15:00 AM	0
4/11/2025	9:30:00 AM	0
4/11/2025	9:45:00 AM	0
4/11/2025	10:00:00 AM	0
4/11/2025	10:15:00 AM	0
4/11/2025	10:30:00 AM	0
4/11/2025	10:45:00 AM	0
4/11/2025	11:00:00 AM	0
4/11/2025	11:15:00 AM	0
4/11/2025	11:30:00 AM	0
4/11/2025	11:45:00 AM	0
4/11/2025	12:00:00 PM	0
4/11/2025	12:15:00 PM	0
4/11/2025	12:30:00 PM	0
4/11/2025	12:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/11/2025	1:00:00 PM	0
4/11/2025	1:15:00 PM	0
4/11/2025	1:30:00 PM	0
4/11/2025	1:45:00 PM	0
4/11/2025	2:00:00 PM	0
4/11/2025	2:15:00 PM	0
4/11/2025	2:30:00 PM	0
4/11/2025	2:45:00 PM	0
4/11/2025	3:00:00 PM	0
4/11/2025	3:15:00 PM	0
4/11/2025	3:30:00 PM	0
4/11/2025	3:45:00 PM	0
4/11/2025	4:00:00 PM	0
4/11/2025	4:15:00 PM	0
4/11/2025	4:30:00 PM	0
4/11/2025	4:45:00 PM	0
4/11/2025	5:00:00 PM	0
4/11/2025	5:15:00 PM	0
4/11/2025	5:30:00 PM	0
4/11/2025	5:45:00 PM	0
4/11/2025	6:00:00 PM	0
4/11/2025	6:15:00 PM	0
4/11/2025	6:30:00 PM	0
4/11/2025	6:45:00 PM	0
4/11/2025	7:00:00 PM	0
4/11/2025	7:15:00 PM	0
4/11/2025	7:30:00 PM	0
4/11/2025	7:45:00 PM	0
4/11/2025	8:00:00 PM	0
4/11/2025	8:15:00 PM	0
4/11/2025	8:30:00 PM	0
4/11/2025	8:45:00 PM	0
4/11/2025	9:00:00 PM	0
4/11/2025	9:15:00 PM	0
4/11/2025	9:30:00 PM	0
4/11/2025	9:45:00 PM	0
4/11/2025	10:00:00 PM	0
4/11/2025	10:15:00 PM	0
4/11/2025	10:30:00 PM	0
4/11/2025	10:45:00 PM	0
4/11/2025	11:00:00 PM	0
4/11/2025	11:15:00 PM	0
4/11/2025	11:30:00 PM	0
4/11/2025	11:45:00 PM	0
4/12/2025	12:00:00 AM	0
4/12/2025	12:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/12/2025	12:30:00 AM	0
4/12/2025	12:45:00 AM	0
4/12/2025	1:00:00 AM	0
4/12/2025	1:15:00 AM	0
4/12/2025	1:30:00 AM	0
4/12/2025	1:45:00 AM	0
4/12/2025	2:00:00 AM	0
4/12/2025	2:15:00 AM	0
4/12/2025	2:30:00 AM	0
4/12/2025	2:45:00 AM	0
4/12/2025	3:00:00 AM	0
4/12/2025	3:15:00 AM	0
4/12/2025	3:30:00 AM	0
4/12/2025	3:45:00 AM	0
4/12/2025	4:00:00 AM	0
4/12/2025	4:15:00 AM	0
4/12/2025	4:30:00 AM	0
4/12/2025	4:45:00 AM	0
4/12/2025	5:00:00 AM	0
4/12/2025	5:15:00 AM	0
4/12/2025	5:30:00 AM	0
4/12/2025	5:45:00 AM	0
4/12/2025	6:00:00 AM	0
4/12/2025	6:15:00 AM	0
4/12/2025	6:30:00 AM	0
4/12/2025	6:45:00 AM	0
4/12/2025	7:00:00 AM	0
4/12/2025	7:15:00 AM	0
4/12/2025	7:30:00 AM	0
4/12/2025	7:45:00 AM	0
4/12/2025	8:00:00 AM	0
4/12/2025	8:15:00 AM	0
4/12/2025	8:30:00 AM	0
4/12/2025	8:45:00 AM	0
4/12/2025	9:00:00 AM	0
4/12/2025	9:15:00 AM	0
4/12/2025	9:30:00 AM	0
4/12/2025	9:45:00 AM	0
4/12/2025	10:00:00 AM	0
4/12/2025	10:15:00 AM	0
4/12/2025	10:30:00 AM	0
4/12/2025	10:45:00 AM	0
4/12/2025	11:00:00 AM	0
4/12/2025	11:15:00 AM	0
4/12/2025	11:30:00 AM	0
4/12/2025	11:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/12/2025	12:00:00 PM	0
4/12/2025	12:15:00 PM	0
4/12/2025	12:30:00 PM	0
4/12/2025	12:45:00 PM	0
4/12/2025	1:00:00 PM	0
4/12/2025	1:15:00 PM	0
4/12/2025	1:30:00 PM	0
4/12/2025	1:45:00 PM	0
4/12/2025	2:00:00 PM	0
4/12/2025	2:15:00 PM	0
4/12/2025	2:30:00 PM	0
4/12/2025	2:45:00 PM	0
4/12/2025	3:00:00 PM	0
4/12/2025	3:15:00 PM	0
4/12/2025	3:30:00 PM	0
4/12/2025	3:45:00 PM	0
4/12/2025	4:00:00 PM	0
4/12/2025	4:15:00 PM	0
4/12/2025	4:30:00 PM	0
4/12/2025	4:45:00 PM	0
4/12/2025	5:00:00 PM	0
4/12/2025	5:15:00 PM	0
4/12/2025	5:30:00 PM	0
4/12/2025	5:45:00 PM	0
4/12/2025	6:00:00 PM	0
4/12/2025	6:15:00 PM	0
4/12/2025	6:30:00 PM	0
4/12/2025	6:45:00 PM	0
4/12/2025	7:00:00 PM	0
4/12/2025	7:15:00 PM	0
4/12/2025	7:30:00 PM	0
4/12/2025	7:45:00 PM	0
4/12/2025	8:00:00 PM	0
4/12/2025	8:15:00 PM	0
4/12/2025	8:30:00 PM	0
4/12/2025	8:45:00 PM	0
4/12/2025	9:00:00 PM	0
4/12/2025	9:15:00 PM	0
4/12/2025	9:30:00 PM	0
4/12/2025	9:45:00 PM	0
4/12/2025	10:00:00 PM	0
4/12/2025	10:15:00 PM	0
4/12/2025	10:30:00 PM	0
4/12/2025	10:45:00 PM	0
4/12/2025	11:00:00 PM	0
4/12/2025	11:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/12/2025	11:30:00 PM	0
4/12/2025	11:45:00 PM	0
4/13/2025	12:00:00 AM	0
4/13/2025	12:15:00 AM	0
4/13/2025	12:30:00 AM	0
4/13/2025	12:45:00 AM	0
4/13/2025	1:00:00 AM	0
4/13/2025	1:15:00 AM	0
4/13/2025	1:30:00 AM	0
4/13/2025	1:45:00 AM	0
4/13/2025	2:00:00 AM	0
4/13/2025	2:15:00 AM	0
4/13/2025	2:30:00 AM	0
4/13/2025	2:45:00 AM	0
4/13/2025	3:00:00 AM	0
4/13/2025	3:15:00 AM	0
4/13/2025	3:30:00 AM	0
4/13/2025	3:45:00 AM	0
4/13/2025	4:00:00 AM	0
4/13/2025	4:15:00 AM	0
4/13/2025	4:30:00 AM	0
4/13/2025	4:45:00 AM	0
4/13/2025	5:00:00 AM	0
4/13/2025	5:15:00 AM	0
4/13/2025	5:30:00 AM	0
4/13/2025	5:45:00 AM	0
4/13/2025	6:00:00 AM	0
4/13/2025	6:15:00 AM	0
4/13/2025	6:30:00 AM	0
4/13/2025	6:45:00 AM	0
4/13/2025	7:00:00 AM	0
4/13/2025	7:15:00 AM	0
4/13/2025	7:30:00 AM	0
4/13/2025	7:45:00 AM	0
4/13/2025	8:00:00 AM	0
4/13/2025	8:15:00 AM	0
4/13/2025	8:30:00 AM	0
4/13/2025	8:45:00 AM	0
4/13/2025	9:00:00 AM	0
4/13/2025	9:15:00 AM	0
4/13/2025	9:30:00 AM	0
4/13/2025	9:45:00 AM	0
4/13/2025	10:00:00 AM	0
4/13/2025	10:15:00 AM	0
4/13/2025	10:30:00 AM	0
4/13/2025	10:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/13/2025	11:00:00 AM	0
4/13/2025	11:15:00 AM	0
4/13/2025	11:30:00 AM	0
4/13/2025	11:45:00 AM	0
4/13/2025	12:00:00 PM	0
4/13/2025	12:15:00 PM	0
4/13/2025	12:30:00 PM	0
4/13/2025	12:45:00 PM	0
4/13/2025	1:00:00 PM	0
4/13/2025	1:15:00 PM	0
4/13/2025	1:30:00 PM	0
4/13/2025	1:45:00 PM	0
4/13/2025	2:00:00 PM	0
4/13/2025	2:15:00 PM	0
4/13/2025	2:30:00 PM	0
4/13/2025	2:45:00 PM	0
4/13/2025	3:00:00 PM	0
4/13/2025	3:15:00 PM	0
4/13/2025	3:30:00 PM	0
4/13/2025	3:45:00 PM	0
4/13/2025	4:00:00 PM	0
4/13/2025	4:15:00 PM	0
4/13/2025	4:30:00 PM	0
4/13/2025	4:45:00 PM	0
4/13/2025	5:00:00 PM	0
4/13/2025	5:15:00 PM	0
4/13/2025	5:30:00 PM	0
4/13/2025	5:45:00 PM	0
4/13/2025	6:00:00 PM	0
4/13/2025	6:15:00 PM	0
4/13/2025	6:30:00 PM	0
4/13/2025	6:45:00 PM	0
4/13/2025	7:00:00 PM	0
4/13/2025	7:15:00 PM	0
4/13/2025	7:30:00 PM	0
4/13/2025	7:45:00 PM	0
4/13/2025	8:00:00 PM	0
4/13/2025	8:15:00 PM	0
4/13/2025	8:30:00 PM	0
4/13/2025	8:45:00 PM	0
4/13/2025	9:00:00 PM	0
4/13/2025	9:15:00 PM	0
4/13/2025	9:30:00 PM	0
4/13/2025	9:45:00 PM	0
4/13/2025	10:00:00 PM	0
4/13/2025	10:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/13/2025	10:30:00 PM	0
4/13/2025	10:45:00 PM	0
4/13/2025	11:00:00 PM	0
4/13/2025	11:15:00 PM	0
4/13/2025	11:30:00 PM	0
4/13/2025	11:45:00 PM	0
4/14/2025	12:00:00 AM	0
4/14/2025	12:15:00 AM	0
4/14/2025	12:30:00 AM	0
4/14/2025	12:45:00 AM	0
4/14/2025	1:00:00 AM	0
4/14/2025	1:15:00 AM	0
4/14/2025	1:30:00 AM	0
4/14/2025	1:45:00 AM	0
4/14/2025	2:00:00 AM	0
4/14/2025	2:15:00 AM	0
4/14/2025	2:30:00 AM	0
4/14/2025	2:45:00 AM	0
4/14/2025	3:00:00 AM	0
4/14/2025	3:15:00 AM	0
4/14/2025	3:30:00 AM	0
4/14/2025	3:45:00 AM	0
4/14/2025	4:00:00 AM	0
4/14/2025	4:15:00 AM	0
4/14/2025	4:30:00 AM	0
4/14/2025	4:45:00 AM	0
4/14/2025	5:00:00 AM	0
4/14/2025	5:15:00 AM	0
4/14/2025	5:30:00 AM	0
4/14/2025	5:45:00 AM	0
4/14/2025	6:00:00 AM	0
4/14/2025	6:15:00 AM	0
4/14/2025	6:30:00 AM	0
4/14/2025	6:45:00 AM	0
4/14/2025	7:00:00 AM	0
4/14/2025	7:15:00 AM	0
4/14/2025	7:30:00 AM	0
4/14/2025	7:45:00 AM	0
4/14/2025	8:00:00 AM	0
4/14/2025	8:15:00 AM	0
4/14/2025	8:30:00 AM	0
4/14/2025	8:45:00 AM	0
4/14/2025	9:00:00 AM	0
4/14/2025	9:15:00 AM	0
4/14/2025	9:30:00 AM	0
4/14/2025	9:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/14/2025	10:00:00 AM	0
4/14/2025	10:15:00 AM	0
4/14/2025	10:30:00 AM	0
4/14/2025	10:45:00 AM	0
4/14/2025	11:00:00 AM	0
4/14/2025	11:15:00 AM	0
4/14/2025	11:30:00 AM	0
4/14/2025	11:45:00 AM	0
4/14/2025	12:00:00 PM	0
4/14/2025	12:15:00 PM	0
4/14/2025	12:30:00 PM	0
4/14/2025	12:45:00 PM	0
4/14/2025	1:00:00 PM	0
4/14/2025	1:15:00 PM	0
4/14/2025	1:30:00 PM	0
4/14/2025	1:45:00 PM	0
4/14/2025	2:00:00 PM	0
4/14/2025	2:15:00 PM	0
4/14/2025	2:30:00 PM	0
4/14/2025	2:45:00 PM	0
4/14/2025	3:00:00 PM	0
4/14/2025	3:15:00 PM	0
4/14/2025	3:30:00 PM	0
4/14/2025	3:45:00 PM	0
4/14/2025	4:00:00 PM	0
4/14/2025	4:15:00 PM	0
4/14/2025	4:30:00 PM	0
4/14/2025	4:45:00 PM	0
4/14/2025	5:00:00 PM	0
4/14/2025	5:15:00 PM	0
4/14/2025	5:30:00 PM	0
4/14/2025	5:45:00 PM	0
4/14/2025	6:00:00 PM	0
4/14/2025	6:15:00 PM	0
4/14/2025	6:30:00 PM	0
4/14/2025	6:45:00 PM	0
4/14/2025	7:00:00 PM	0
4/14/2025	7:15:00 PM	0
4/14/2025	7:30:00 PM	0
4/14/2025	7:45:00 PM	0
4/14/2025	8:00:00 PM	0
4/14/2025	8:15:00 PM	0
4/14/2025	8:30:00 PM	0
4/14/2025	8:45:00 PM	0
4/14/2025	9:00:00 PM	0
4/14/2025	9:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/14/2025	9:30:00 PM	0
4/14/2025	9:45:00 PM	0
4/14/2025	10:00:00 PM	0
4/14/2025	10:15:00 PM	0
4/14/2025	10:30:00 PM	0
4/14/2025	10:45:00 PM	0
4/14/2025	11:00:00 PM	0
4/14/2025	11:15:00 PM	0
4/14/2025	11:30:00 PM	0
4/14/2025	11:45:00 PM	0
4/15/2025	12:00:00 AM	0
4/15/2025	12:15:00 AM	0
4/15/2025	12:30:00 AM	0
4/15/2025	12:45:00 AM	0
4/15/2025	1:00:00 AM	0
4/15/2025	1:15:00 AM	0
4/15/2025	1:30:00 AM	0
4/15/2025	1:45:00 AM	0
4/15/2025	2:00:00 AM	0
4/15/2025	2:15:00 AM	0
4/15/2025	2:30:00 AM	0
4/15/2025	2:45:00 AM	0
4/15/2025	3:00:00 AM	0
4/15/2025	3:15:00 AM	0
4/15/2025	3:30:00 AM	0
4/15/2025	3:45:00 AM	0
4/15/2025	4:00:00 AM	0
4/15/2025	4:15:00 AM	0
4/15/2025	4:30:00 AM	0
4/15/2025	4:45:00 AM	0
4/15/2025	5:00:00 AM	0
4/15/2025	5:15:00 AM	0
4/15/2025	5:30:00 AM	0
4/15/2025	5:45:00 AM	0
4/15/2025	6:00:00 AM	0
4/15/2025	6:15:00 AM	0
4/15/2025	6:30:00 AM	0
4/15/2025	6:45:00 AM	0
4/15/2025	7:00:00 AM	0
4/15/2025	7:15:00 AM	0
4/15/2025	7:30:00 AM	0
4/15/2025	7:45:00 AM	0
4/15/2025	8:00:00 AM	0
4/15/2025	8:15:00 AM	0
4/15/2025	8:30:00 AM	0
4/15/2025	8:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/15/2025	9:00:00 AM	0
4/15/2025	9:15:00 AM	0
4/15/2025	9:30:00 AM	0
4/15/2025	9:45:00 AM	0
4/15/2025	10:00:00 AM	0
4/15/2025	10:15:00 AM	0
4/15/2025	10:30:00 AM	0
4/15/2025	10:45:00 AM	0
4/15/2025	11:00:00 AM	0
4/15/2025	11:15:00 AM	0
4/15/2025	11:30:00 AM	0
4/15/2025	11:45:00 AM	0
4/15/2025	12:00:00 PM	0
4/15/2025	12:15:00 PM	0
4/15/2025	12:30:00 PM	0
4/15/2025	12:45:00 PM	0
4/15/2025	1:00:00 PM	0
4/15/2025	1:15:00 PM	0
4/15/2025	1:30:00 PM	0
4/15/2025	1:45:00 PM	0
4/15/2025	2:00:00 PM	0
4/15/2025	2:15:00 PM	0
4/15/2025	2:30:00 PM	0
4/15/2025	2:45:00 PM	0
4/15/2025	3:00:00 PM	0
4/15/2025	3:15:00 PM	0
4/15/2025	3:30:00 PM	0
4/15/2025	3:45:00 PM	0
4/15/2025	4:00:00 PM	0
4/15/2025	4:15:00 PM	0
4/15/2025	4:30:00 PM	0
4/15/2025	4:45:00 PM	0
4/15/2025	5:00:00 PM	0
4/15/2025	5:15:00 PM	0
4/15/2025	5:30:00 PM	0
4/15/2025	5:45:00 PM	0
4/15/2025	6:00:00 PM	0
4/15/2025	6:15:00 PM	0
4/15/2025	6:30:00 PM	0
4/15/2025	6:45:00 PM	0
4/15/2025	7:00:00 PM	0
4/15/2025	7:15:00 PM	0
4/15/2025	7:30:00 PM	0
4/15/2025	7:45:00 PM	0
4/15/2025	8:00:00 PM	0
4/15/2025	8:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/15/2025	8:30:00 PM	0
4/15/2025	8:45:00 PM	0
4/15/2025	9:00:00 PM	0
4/15/2025	9:15:00 PM	0
4/15/2025	9:30:00 PM	0
4/15/2025	9:45:00 PM	0
4/15/2025	10:00:00 PM	0
4/15/2025	10:15:00 PM	0
4/15/2025	10:30:00 PM	0
4/15/2025	10:45:00 PM	0
4/15/2025	11:00:00 PM	0
4/15/2025	11:15:00 PM	0
4/15/2025	11:30:00 PM	0
4/15/2025	11:45:00 PM	0
4/16/2025	12:00:00 AM	0
4/16/2025	12:15:00 AM	0
4/16/2025	12:30:00 AM	0
4/16/2025	12:45:00 AM	0
4/16/2025	1:00:00 AM	0
4/16/2025	1:15:00 AM	0
4/16/2025	1:30:00 AM	0
4/16/2025	1:45:00 AM	0
4/16/2025	2:00:00 AM	0
4/16/2025	2:15:00 AM	0
4/16/2025	2:30:00 AM	0
4/16/2025	2:45:00 AM	0
4/16/2025	3:00:00 AM	0
4/16/2025	3:15:00 AM	0
4/16/2025	3:30:00 AM	0
4/16/2025	3:45:00 AM	0
4/16/2025	4:00:00 AM	0
4/16/2025	4:15:00 AM	0
4/16/2025	4:30:00 AM	0
4/16/2025	4:45:00 AM	0
4/16/2025	5:00:00 AM	0
4/16/2025	5:15:00 AM	0
4/16/2025	5:30:00 AM	0
4/16/2025	5:45:00 AM	0
4/16/2025	6:00:00 AM	0
4/16/2025	6:15:00 AM	0
4/16/2025	6:30:00 AM	0
4/16/2025	6:45:00 AM	0
4/16/2025	7:00:00 AM	0
4/16/2025	7:15:00 AM	0
4/16/2025	7:30:00 AM	0
4/16/2025	7:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/16/2025	8:00:00 AM	0
4/16/2025	8:15:00 AM	0
4/16/2025	8:30:00 AM	0
4/16/2025	8:45:00 AM	0
4/16/2025	9:00:00 AM	0
4/16/2025	9:15:00 AM	0
4/16/2025	9:30:00 AM	0
4/16/2025	9:45:00 AM	0
4/16/2025	10:00:00 AM	0
4/16/2025	10:15:00 AM	0
4/16/2025	10:30:00 AM	0
4/16/2025	10:45:00 AM	0
4/16/2025	11:00:00 AM	0
4/16/2025	11:15:00 AM	0
4/16/2025	11:30:00 AM	0
4/16/2025	11:45:00 AM	0
4/16/2025	12:00:00 PM	0
4/16/2025	12:15:00 PM	0
4/16/2025	12:30:00 PM	0
4/16/2025	12:45:00 PM	0
4/16/2025	1:00:00 PM	0
4/16/2025	1:15:00 PM	0
4/16/2025	1:30:00 PM	0
4/16/2025	1:45:00 PM	0
4/16/2025	2:00:00 PM	0
4/16/2025	2:15:00 PM	0
4/16/2025	2:30:00 PM	0
4/16/2025	2:45:00 PM	0
4/16/2025	3:00:00 PM	0
4/16/2025	3:15:00 PM	0
4/16/2025	3:30:00 PM	0
4/16/2025	3:45:00 PM	0
4/16/2025	4:00:00 PM	0
4/16/2025	4:15:00 PM	0
4/16/2025	4:30:00 PM	0
4/16/2025	4:45:00 PM	0
4/16/2025	5:00:00 PM	0
4/16/2025	5:15:00 PM	0
4/16/2025	5:30:00 PM	0
4/16/2025	5:45:00 PM	0
4/16/2025	6:00:00 PM	0
4/16/2025	6:15:00 PM	0
4/16/2025	6:30:00 PM	0
4/16/2025	6:45:00 PM	0
4/16/2025	7:00:00 PM	0
4/16/2025	7:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/16/2025	7:30:00 PM	0
4/16/2025	7:45:00 PM	0
4/16/2025	8:00:00 PM	0
4/16/2025	8:15:00 PM	0
4/16/2025	8:30:00 PM	0
4/16/2025	8:45:00 PM	0
4/16/2025	9:00:00 PM	0
4/16/2025	9:15:00 PM	0
4/16/2025	9:30:00 PM	0
4/16/2025	9:45:00 PM	0
4/16/2025	10:00:00 PM	0
4/16/2025	10:15:00 PM	0
4/16/2025	10:30:00 PM	0
4/16/2025	10:45:00 PM	0
4/16/2025	11:00:00 PM	0
4/16/2025	11:15:00 PM	0
4/16/2025	11:30:00 PM	0
4/16/2025	11:45:00 PM	0
4/17/2025	12:00:00 AM	0
4/17/2025	12:15:00 AM	0
4/17/2025	12:30:00 AM	0
4/17/2025	12:45:00 AM	0
4/17/2025	1:00:00 AM	0
4/17/2025	1:15:00 AM	0
4/17/2025	1:30:00 AM	0
4/17/2025	1:45:00 AM	0
4/17/2025	2:00:00 AM	0
4/17/2025	2:15:00 AM	0
4/17/2025	2:30:00 AM	0
4/17/2025	2:45:00 AM	0
4/17/2025	3:00:00 AM	0
4/17/2025	3:15:00 AM	0
4/17/2025	3:30:00 AM	0
4/17/2025	3:45:00 AM	0
4/17/2025	4:00:00 AM	0
4/17/2025	4:15:00 AM	0
4/17/2025	4:30:00 AM	0
4/17/2025	4:45:00 AM	0
4/17/2025	5:00:00 AM	0
4/17/2025	5:15:00 AM	0
4/17/2025	5:30:00 AM	0
4/17/2025	5:45:00 AM	0
4/17/2025	6:00:00 AM	0
4/17/2025	6:15:00 AM	0
4/17/2025	6:30:00 AM	0
4/17/2025	6:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/17/2025	7:00:00 AM	0
4/17/2025	7:15:00 AM	0
4/17/2025	7:30:00 AM	0
4/17/2025	7:45:00 AM	0
4/17/2025	8:00:00 AM	0
4/17/2025	8:15:00 AM	0
4/17/2025	8:30:00 AM	0
4/17/2025	8:45:00 AM	0
4/17/2025	9:00:00 AM	0
4/17/2025	9:15:00 AM	0
4/17/2025	9:30:00 AM	0
4/17/2025	9:45:00 AM	0
4/17/2025	10:00:00 AM	0
4/17/2025	10:15:00 AM	0
4/17/2025	10:30:00 AM	0
4/17/2025	10:45:00 AM	0
4/17/2025	11:00:00 AM	0
4/17/2025	11:15:00 AM	0
4/17/2025	11:30:00 AM	0
4/17/2025	11:45:00 AM	0
4/17/2025	12:00:00 PM	0
4/17/2025	12:15:00 PM	0
4/17/2025	12:30:00 PM	0
4/17/2025	12:45:00 PM	0
4/17/2025	1:00:00 PM	0
4/17/2025	1:15:00 PM	0
4/17/2025	1:30:00 PM	0
4/17/2025	1:45:00 PM	0
4/17/2025	2:00:00 PM	0
4/17/2025	2:15:00 PM	0
4/17/2025	2:30:00 PM	0
4/17/2025	2:45:00 PM	0
4/17/2025	3:00:00 PM	0
4/17/2025	3:15:00 PM	0
4/17/2025	3:30:00 PM	0
4/17/2025	3:45:00 PM	0
4/17/2025	4:00:00 PM	0
4/17/2025	4:15:00 PM	0
4/17/2025	4:30:00 PM	0
4/17/2025	4:45:00 PM	0
4/17/2025	5:00:00 PM	0
4/17/2025	5:15:00 PM	0
4/17/2025	5:30:00 PM	0
4/17/2025	5:45:00 PM	0
4/17/2025	6:00:00 PM	0
4/17/2025	6:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/17/2025	6:30:00 PM	0
4/17/2025	6:45:00 PM	0
4/17/2025	7:00:00 PM	0
4/17/2025	7:15:00 PM	0
4/17/2025	7:30:00 PM	0
4/17/2025	7:45:00 PM	0
4/17/2025	8:00:00 PM	0
4/17/2025	8:15:00 PM	0
4/17/2025	8:30:00 PM	0
4/17/2025	8:45:00 PM	0
4/17/2025	9:00:00 PM	0
4/17/2025	9:15:00 PM	0
4/17/2025	9:30:00 PM	0
4/17/2025	9:45:00 PM	0
4/17/2025	10:00:00 PM	0
4/17/2025	10:15:00 PM	0
4/17/2025	10:30:00 PM	0
4/17/2025	10:45:00 PM	0
4/17/2025	11:00:00 PM	0
4/17/2025	11:15:00 PM	0
4/17/2025	11:30:00 PM	0
4/17/2025	11:45:00 PM	0
4/18/2025	12:00:00 AM	0
4/18/2025	12:15:00 AM	0
4/18/2025	12:30:00 AM	0
4/18/2025	12:45:00 AM	0
4/18/2025	1:00:00 AM	0
4/18/2025	1:15:00 AM	0
4/18/2025	1:30:00 AM	0
4/18/2025	1:45:00 AM	0
4/18/2025	2:00:00 AM	0
4/18/2025	2:15:00 AM	0
4/18/2025	2:30:00 AM	0
4/18/2025	2:45:00 AM	0
4/18/2025	3:00:00 AM	0
4/18/2025	3:15:00 AM	0
4/18/2025	3:30:00 AM	0
4/18/2025	3:45:00 AM	0
4/18/2025	4:00:00 AM	0
4/18/2025	4:15:00 AM	0
4/18/2025	4:30:00 AM	0
4/18/2025	4:45:00 AM	0
4/18/2025	5:00:00 AM	0
4/18/2025	5:15:00 AM	0
4/18/2025	5:30:00 AM	0
4/18/2025	5:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/18/2025	6:00:00 AM	0
4/18/2025	6:15:00 AM	0
4/18/2025	6:30:00 AM	0
4/18/2025	6:45:00 AM	0
4/18/2025	7:00:00 AM	0
4/18/2025	7:15:00 AM	0
4/18/2025	7:30:00 AM	0
4/18/2025	7:45:00 AM	0
4/18/2025	8:00:00 AM	0
4/18/2025	8:15:00 AM	0
4/18/2025	8:30:00 AM	0
4/18/2025	8:45:00 AM	0
4/18/2025	9:00:00 AM	0
4/18/2025	9:15:00 AM	0
4/18/2025	9:30:00 AM	0
4/18/2025	9:45:00 AM	0
4/18/2025	10:00:00 AM	0
4/18/2025	10:15:00 AM	0
4/18/2025	10:30:00 AM	0
4/18/2025	10:45:00 AM	0
4/18/2025	11:00:00 AM	0
4/18/2025	11:15:00 AM	0
4/18/2025	11:30:00 AM	0
4/18/2025	11:45:00 AM	0
4/18/2025	12:00:00 PM	0
4/18/2025	12:15:00 PM	0
4/18/2025	12:30:00 PM	0
4/18/2025	12:45:00 PM	0
4/18/2025	1:00:00 PM	0
4/18/2025	1:15:00 PM	0
4/18/2025	1:30:00 PM	0
4/18/2025	1:45:00 PM	0
4/18/2025	2:00:00 PM	0
4/18/2025	2:15:00 PM	0
4/18/2025	2:30:00 PM	0
4/18/2025	2:45:00 PM	0
4/18/2025	3:00:00 PM	0
4/18/2025	3:15:00 PM	0
4/18/2025	3:30:00 PM	0
4/18/2025	3:45:00 PM	0
4/18/2025	4:00:00 PM	0
4/18/2025	4:15:00 PM	0
4/18/2025	4:30:00 PM	0
4/18/2025	4:45:00 PM	0
4/18/2025	5:00:00 PM	0
4/18/2025	5:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/18/2025	5:30:00 PM	0
4/18/2025	5:45:00 PM	0
4/18/2025	6:00:00 PM	0
4/18/2025	6:15:00 PM	0
4/18/2025	6:30:00 PM	0
4/18/2025	6:45:00 PM	0
4/18/2025	7:00:00 PM	0
4/18/2025	7:15:00 PM	0
4/18/2025	7:30:00 PM	0
4/18/2025	7:45:00 PM	0
4/18/2025	8:00:00 PM	0
4/18/2025	8:15:00 PM	0
4/18/2025	8:30:00 PM	0
4/18/2025	8:45:00 PM	0
4/18/2025	9:00:00 PM	0
4/18/2025	9:15:00 PM	0
4/18/2025	9:30:00 PM	0
4/18/2025	9:45:00 PM	0
4/18/2025	10:00:00 PM	0
4/18/2025	10:15:00 PM	0
4/18/2025	10:30:00 PM	0
4/18/2025	10:45:00 PM	0
4/18/2025	11:00:00 PM	0
4/18/2025	11:15:00 PM	0
4/18/2025	11:30:00 PM	0
4/18/2025	11:45:00 PM	0
4/19/2025	12:00:00 AM	0
4/19/2025	12:15:00 AM	0
4/19/2025	12:30:00 AM	0
4/19/2025	12:45:00 AM	0
4/19/2025	1:00:00 AM	0
4/19/2025	1:15:00 AM	0
4/19/2025	1:30:00 AM	0
4/19/2025	1:45:00 AM	0
4/19/2025	2:00:00 AM	0
4/19/2025	2:15:00 AM	0
4/19/2025	2:30:00 AM	0
4/19/2025	2:45:00 AM	0
4/19/2025	3:00:00 AM	0
4/19/2025	3:15:00 AM	0
4/19/2025	3:30:00 AM	0
4/19/2025	3:45:00 AM	0
4/19/2025	4:00:00 AM	0
4/19/2025	4:15:00 AM	0
4/19/2025	4:30:00 AM	0
4/19/2025	4:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/19/2025	5:00:00 AM	0
4/19/2025	5:15:00 AM	0
4/19/2025	5:30:00 AM	0
4/19/2025	5:45:00 AM	0
4/19/2025	6:00:00 AM	0
4/19/2025	6:15:00 AM	0
4/19/2025	6:30:00 AM	0
4/19/2025	6:45:00 AM	0
4/19/2025	7:00:00 AM	0
4/19/2025	7:15:00 AM	0
4/19/2025	7:30:00 AM	0
4/19/2025	7:45:00 AM	0
4/19/2025	8:00:00 AM	0
4/19/2025	8:15:00 AM	0
4/19/2025	8:30:00 AM	0
4/19/2025	8:45:00 AM	0
4/19/2025	9:00:00 AM	0
4/19/2025	9:15:00 AM	0
4/19/2025	9:30:00 AM	0
4/19/2025	9:45:00 AM	0
4/19/2025	10:00:00 AM	0
4/19/2025	10:15:00 AM	0
4/19/2025	10:30:00 AM	0
4/19/2025	10:45:00 AM	0
4/19/2025	11:00:00 AM	0
4/19/2025	11:15:00 AM	0
4/19/2025	11:30:00 AM	0
4/19/2025	11:45:00 AM	0
4/19/2025	12:00:00 PM	0
4/19/2025	12:15:00 PM	0
4/19/2025	12:30:00 PM	0
4/19/2025	12:45:00 PM	0
4/19/2025	1:00:00 PM	0
4/19/2025	1:15:00 PM	0
4/19/2025	1:30:00 PM	0
4/19/2025	1:45:00 PM	0
4/19/2025	2:00:00 PM	0
4/19/2025	2:15:00 PM	0
4/19/2025	2:30:00 PM	0
4/19/2025	2:45:00 PM	0
4/19/2025	3:00:00 PM	0
4/19/2025	3:15:00 PM	0
4/19/2025	3:30:00 PM	0
4/19/2025	3:45:00 PM	0
4/19/2025	4:00:00 PM	0
4/19/2025	4:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/19/2025	4:30:00 PM	0
4/19/2025	4:45:00 PM	0
4/19/2025	5:00:00 PM	0
4/19/2025	5:15:00 PM	0
4/19/2025	5:30:00 PM	0
4/19/2025	5:45:00 PM	0
4/19/2025	6:00:00 PM	0
4/19/2025	6:15:00 PM	0
4/19/2025	6:30:00 PM	0
4/19/2025	6:45:00 PM	0
4/19/2025	7:00:00 PM	0
4/19/2025	7:15:00 PM	0
4/19/2025	7:30:00 PM	0
4/19/2025	7:45:00 PM	0
4/19/2025	8:00:00 PM	0
4/19/2025	8:15:00 PM	0
4/19/2025	8:30:00 PM	0
4/19/2025	8:45:00 PM	0
4/19/2025	9:00:00 PM	0
4/19/2025	9:15:00 PM	0
4/19/2025	9:30:00 PM	0
4/19/2025	9:45:00 PM	0
4/19/2025	10:00:00 PM	0
4/19/2025	10:15:00 PM	0
4/19/2025	10:30:00 PM	0
4/19/2025	10:45:00 PM	0
4/19/2025	11:00:00 PM	0
4/19/2025	11:15:00 PM	0
4/19/2025	11:30:00 PM	0
4/19/2025	11:45:00 PM	0
4/20/2025	12:00:00 AM	0
4/20/2025	12:15:00 AM	0
4/20/2025	12:30:00 AM	0
4/20/2025	12:45:00 AM	0
4/20/2025	1:00:00 AM	0
4/20/2025	1:15:00 AM	0
4/20/2025	1:30:00 AM	0
4/20/2025	1:45:00 AM	0
4/20/2025	2:00:00 AM	0
4/20/2025	2:15:00 AM	0
4/20/2025	2:30:00 AM	0
4/20/2025	2:45:00 AM	0
4/20/2025	3:00:00 AM	0
4/20/2025	3:15:00 AM	0
4/20/2025	3:30:00 AM	0
4/20/2025	3:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/20/2025	4:00:00 AM	0
4/20/2025	4:15:00 AM	0
4/20/2025	4:30:00 AM	0
4/20/2025	4:45:00 AM	0
4/20/2025	5:00:00 AM	0
4/20/2025	5:15:00 AM	0
4/20/2025	5:30:00 AM	0
4/20/2025	5:45:00 AM	0
4/20/2025	6:00:00 AM	0
4/20/2025	6:15:00 AM	0
4/20/2025	6:30:00 AM	0
4/20/2025	6:45:00 AM	0
4/20/2025	7:00:00 AM	0
4/20/2025	7:15:00 AM	0
4/20/2025	7:30:00 AM	0
4/20/2025	7:45:00 AM	0
4/20/2025	8:00:00 AM	0
4/20/2025	8:15:00 AM	0
4/20/2025	8:30:00 AM	0
4/20/2025	8:45:00 AM	0
4/20/2025	9:00:00 AM	0
4/20/2025	9:15:00 AM	0
4/20/2025	9:30:00 AM	0
4/20/2025	9:45:00 AM	0
4/20/2025	10:00:00 AM	0
4/20/2025	10:15:00 AM	0
4/20/2025	10:30:00 AM	0
4/20/2025	10:45:00 AM	0
4/20/2025	11:00:00 AM	0
4/20/2025	11:15:00 AM	0
4/20/2025	11:30:00 AM	0
4/20/2025	11:45:00 AM	0
4/20/2025	12:00:00 PM	0
4/20/2025	12:15:00 PM	0
4/20/2025	12:30:00 PM	0
4/20/2025	12:45:00 PM	0
4/20/2025	1:00:00 PM	0
4/20/2025	1:15:00 PM	0
4/20/2025	1:30:00 PM	0
4/20/2025	1:45:00 PM	0
4/20/2025	2:00:00 PM	0
4/20/2025	2:15:00 PM	0
4/20/2025	2:30:00 PM	0
4/20/2025	2:45:00 PM	0
4/20/2025	3:00:00 PM	0
4/20/2025	3:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/20/2025	3:30:00 PM	0
4/20/2025	3:45:00 PM	0
4/20/2025	4:00:00 PM	0
4/20/2025	4:15:00 PM	0
4/20/2025	4:30:00 PM	0
4/20/2025	4:45:00 PM	0
4/20/2025	5:00:00 PM	0
4/20/2025	5:15:00 PM	0
4/20/2025	5:30:00 PM	0
4/20/2025	5:45:00 PM	0
4/20/2025	6:00:00 PM	0
4/20/2025	6:15:00 PM	0
4/20/2025	6:30:00 PM	0
4/20/2025	6:45:00 PM	0
4/20/2025	7:00:00 PM	0
4/20/2025	7:15:00 PM	0
4/20/2025	7:30:00 PM	0
4/20/2025	7:45:00 PM	0
4/20/2025	8:00:00 PM	0
4/20/2025	8:15:00 PM	0
4/20/2025	8:30:00 PM	0
4/20/2025	8:45:00 PM	0
4/20/2025	9:00:00 PM	0
4/20/2025	9:15:00 PM	0
4/20/2025	9:30:00 PM	0
4/20/2025	9:45:00 PM	0
4/20/2025	10:00:00 PM	0
4/20/2025	10:15:00 PM	0
4/20/2025	10:30:00 PM	0
4/20/2025	10:45:00 PM	0
4/20/2025	11:00:00 PM	0
4/20/2025	11:15:00 PM	0
4/20/2025	11:30:00 PM	0
4/20/2025	11:45:00 PM	0
4/21/2025	12:00:00 AM	0
4/21/2025	12:15:00 AM	0
4/21/2025	12:30:00 AM	0
4/21/2025	12:45:00 AM	0
4/21/2025	1:00:00 AM	0
4/21/2025	1:15:00 AM	0
4/21/2025	1:30:00 AM	0
4/21/2025	1:45:00 AM	0
4/21/2025	2:00:00 AM	0
4/21/2025	2:15:00 AM	0
4/21/2025	2:30:00 AM	0
4/21/2025	2:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/21/2025	3:00:00 AM	0
4/21/2025	3:15:00 AM	0
4/21/2025	3:30:00 AM	0
4/21/2025	3:45:00 AM	0
4/21/2025	4:00:00 AM	0
4/21/2025	4:15:00 AM	0
4/21/2025	4:30:00 AM	0
4/21/2025	4:45:00 AM	0
4/21/2025	5:00:00 AM	0
4/21/2025	5:15:00 AM	0
4/21/2025	5:30:00 AM	0
4/21/2025	5:45:00 AM	0
4/21/2025	6:00:00 AM	0
4/21/2025	6:15:00 AM	0
4/21/2025	6:30:00 AM	0
4/21/2025	6:45:00 AM	0
4/21/2025	7:00:00 AM	0
4/21/2025	7:15:00 AM	0
4/21/2025	7:30:00 AM	0
4/21/2025	7:45:00 AM	0
4/21/2025	8:00:00 AM	0
4/21/2025	8:15:00 AM	0
4/21/2025	8:30:00 AM	0
4/21/2025	8:45:00 AM	0
4/21/2025	9:00:00 AM	0
4/21/2025	9:15:00 AM	0
4/21/2025	9:30:00 AM	0
4/21/2025	9:45:00 AM	0
4/21/2025	10:00:00 AM	0
4/21/2025	10:15:00 AM	0
4/21/2025	10:30:00 AM	0
4/21/2025	10:45:00 AM	0
4/21/2025	11:00:00 AM	0
4/21/2025	11:15:00 AM	0
4/21/2025	11:30:00 AM	0
4/21/2025	11:45:00 AM	0
4/21/2025	12:00:00 PM	0
4/21/2025	12:15:00 PM	0
4/21/2025	12:30:00 PM	0
4/21/2025	12:45:00 PM	0
4/21/2025	1:00:00 PM	0
4/21/2025	1:15:00 PM	0
4/21/2025	1:30:00 PM	0
4/21/2025	1:45:00 PM	0
4/21/2025	2:00:00 PM	0
4/21/2025	2:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/21/2025	2:30:00 PM	0
4/21/2025	2:45:00 PM	0
4/21/2025	3:00:00 PM	0
4/21/2025	3:15:00 PM	0
4/21/2025	3:30:00 PM	0
4/21/2025	3:45:00 PM	0
4/21/2025	4:00:00 PM	0
4/21/2025	4:15:00 PM	0
4/21/2025	4:30:00 PM	0
4/21/2025	4:45:00 PM	0
4/21/2025	5:00:00 PM	0
4/21/2025	5:15:00 PM	0
4/21/2025	5:30:00 PM	0
4/21/2025	5:45:00 PM	0
4/21/2025	6:00:00 PM	0
4/21/2025	6:15:00 PM	0
4/21/2025	6:30:00 PM	0
4/21/2025	6:45:00 PM	0
4/21/2025	7:00:00 PM	0
4/21/2025	7:15:00 PM	0
4/21/2025	7:30:00 PM	0
4/21/2025	7:45:00 PM	0
4/21/2025	8:00:00 PM	0
4/21/2025	8:15:00 PM	0
4/21/2025	8:30:00 PM	0
4/21/2025	8:45:00 PM	0
4/21/2025	9:00:00 PM	0
4/21/2025	9:15:00 PM	0
4/21/2025	9:30:00 PM	0
4/21/2025	9:45:00 PM	0
4/21/2025	10:00:00 PM	0
4/21/2025	10:15:00 PM	0
4/21/2025	10:30:00 PM	0
4/21/2025	10:45:00 PM	0
4/21/2025	11:00:00 PM	0
4/21/2025	11:15:00 PM	0
4/21/2025	11:30:00 PM	0
4/21/2025	11:45:00 PM	0
4/22/2025	12:00:00 AM	0
4/22/2025	12:15:00 AM	0
4/22/2025	12:30:00 AM	0
4/22/2025	12:45:00 AM	0
4/22/2025	1:00:00 AM	0
4/22/2025	1:15:00 AM	0
4/22/2025	1:30:00 AM	0
4/22/2025	1:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/22/2025	2:00:00 AM	0
4/22/2025	2:15:00 AM	0
4/22/2025	2:30:00 AM	0
4/22/2025	2:45:00 AM	0
4/22/2025	3:00:00 AM	0
4/22/2025	3:15:00 AM	0
4/22/2025	3:30:00 AM	0
4/22/2025	3:45:00 AM	0
4/22/2025	4:00:00 AM	0
4/22/2025	4:15:00 AM	0
4/22/2025	4:30:00 AM	0
4/22/2025	4:45:00 AM	0
4/22/2025	5:00:00 AM	0
4/22/2025	5:15:00 AM	0
4/22/2025	5:30:00 AM	0
4/22/2025	5:45:00 AM	0
4/22/2025	6:00:00 AM	0
4/22/2025	6:15:00 AM	0
4/22/2025	6:30:00 AM	0
4/22/2025	6:45:00 AM	0
4/22/2025	7:00:00 AM	0
4/22/2025	7:15:00 AM	0
4/22/2025	7:30:00 AM	0
4/22/2025	7:45:00 AM	0
4/22/2025	8:00:00 AM	0
4/22/2025	8:15:00 AM	0
4/22/2025	8:30:00 AM	0
4/22/2025	8:45:00 AM	0
4/22/2025	9:00:00 AM	0
4/22/2025	9:15:00 AM	0
4/22/2025	9:30:00 AM	0
4/22/2025	9:45:00 AM	0
4/22/2025	10:00:00 AM	0
4/22/2025	10:15:00 AM	0
4/22/2025	10:30:00 AM	0
4/22/2025	10:45:00 AM	0
4/22/2025	11:00:00 AM	0
4/22/2025	11:15:00 AM	0
4/22/2025	11:30:00 AM	0
4/22/2025	11:45:00 AM	0
4/22/2025	12:00:00 PM	0
4/22/2025	12:15:00 PM	0
4/22/2025	12:30:00 PM	0
4/22/2025	12:45:00 PM	0
4/22/2025	1:00:00 PM	0
4/22/2025	1:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/22/2025	1:30:00 PM	0
4/22/2025	1:45:00 PM	0
4/22/2025	2:00:00 PM	0
4/22/2025	2:15:00 PM	0
4/22/2025	2:30:00 PM	0
4/22/2025	2:45:00 PM	0
4/22/2025	3:00:00 PM	0
4/22/2025	3:15:00 PM	0
4/22/2025	3:30:00 PM	0
4/22/2025	3:45:00 PM	0
4/22/2025	4:00:00 PM	0
4/22/2025	4:15:00 PM	0
4/22/2025	4:30:00 PM	0
4/22/2025	4:45:00 PM	0
4/22/2025	5:00:00 PM	0
4/22/2025	5:15:00 PM	0
4/22/2025	5:30:00 PM	0
4/22/2025	5:45:00 PM	0
4/22/2025	6:00:00 PM	0
4/22/2025	6:15:00 PM	0
4/22/2025	6:30:00 PM	0
4/22/2025	6:45:00 PM	0
4/22/2025	7:00:00 PM	0
4/22/2025	7:15:00 PM	0
4/22/2025	7:30:00 PM	0
4/22/2025	7:45:00 PM	0
4/22/2025	8:00:00 PM	0
4/22/2025	8:15:00 PM	0
4/22/2025	8:30:00 PM	0
4/22/2025	8:45:00 PM	0
4/22/2025	9:00:00 PM	0
4/22/2025	9:15:00 PM	0
4/22/2025	9:30:00 PM	0
4/22/2025	9:45:00 PM	0
4/22/2025	10:00:00 PM	0
4/22/2025	10:15:00 PM	0
4/22/2025	10:30:00 PM	0
4/22/2025	10:45:00 PM	0
4/22/2025	11:00:00 PM	0
4/22/2025	11:15:00 PM	0
4/22/2025	11:30:00 PM	0
4/22/2025	11:45:00 PM	0
4/23/2025	12:00:00 AM	0
4/23/2025	12:15:00 AM	0
4/23/2025	12:30:00 AM	0
4/23/2025	12:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/23/2025	1:00:00 AM	0
4/23/2025	1:15:00 AM	0
4/23/2025	1:30:00 AM	0
4/23/2025	1:45:00 AM	0
4/23/2025	2:00:00 AM	0
4/23/2025	2:15:00 AM	0
4/23/2025	2:30:00 AM	0
4/23/2025	2:45:00 AM	0
4/23/2025	3:00:00 AM	0
4/23/2025	3:15:00 AM	0
4/23/2025	3:30:00 AM	0
4/23/2025	3:45:00 AM	0
4/23/2025	4:00:00 AM	0
4/23/2025	4:15:00 AM	0
4/23/2025	4:30:00 AM	0
4/23/2025	4:45:00 AM	0
4/23/2025	5:00:00 AM	0
4/23/2025	5:15:00 AM	0
4/23/2025	5:30:00 AM	0
4/23/2025	5:45:00 AM	0
4/23/2025	6:00:00 AM	0
4/23/2025	6:15:00 AM	0
4/23/2025	6:30:00 AM	0
4/23/2025	6:45:00 AM	0
4/23/2025	7:00:00 AM	0
4/23/2025	7:15:00 AM	0
4/23/2025	7:30:00 AM	0
4/23/2025	7:45:00 AM	0
4/23/2025	8:00:00 AM	0
4/23/2025	8:15:00 AM	0
4/23/2025	8:30:00 AM	0
4/23/2025	8:45:00 AM	0
4/23/2025	9:00:00 AM	0
4/23/2025	9:15:00 AM	0
4/23/2025	9:30:00 AM	0
4/23/2025	9:45:00 AM	0
4/23/2025	10:00:00 AM	0
4/23/2025	10:15:00 AM	0
4/23/2025	10:30:00 AM	0
4/23/2025	10:45:00 AM	0
4/23/2025	11:00:00 AM	0
4/23/2025	11:15:00 AM	0
4/23/2025	11:30:00 AM	0
4/23/2025	11:45:00 AM	0
4/23/2025	12:00:00 PM	0
4/23/2025	12:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/23/2025	12:30:00 PM	0
4/23/2025	12:45:00 PM	0
4/23/2025	1:00:00 PM	0
4/23/2025	1:15:00 PM	0
4/23/2025	1:30:00 PM	0
4/23/2025	1:45:00 PM	0
4/23/2025	2:00:00 PM	0
4/23/2025	2:15:00 PM	0
4/23/2025	2:30:00 PM	0
4/23/2025	2:45:00 PM	0
4/23/2025	3:00:00 PM	0
4/23/2025	3:15:00 PM	0
4/23/2025	3:30:00 PM	0
4/23/2025	3:45:00 PM	0
4/23/2025	4:00:00 PM	0
4/23/2025	4:15:00 PM	0
4/23/2025	4:30:00 PM	0
4/23/2025	4:45:00 PM	0
4/23/2025	5:00:00 PM	0
4/23/2025	5:15:00 PM	0
4/23/2025	5:30:00 PM	0
4/23/2025	5:45:00 PM	0
4/23/2025	6:00:00 PM	0
4/23/2025	6:15:00 PM	0
4/23/2025	6:30:00 PM	0
4/23/2025	6:45:00 PM	0
4/23/2025	7:00:00 PM	0
4/23/2025	7:15:00 PM	0
4/23/2025	7:30:00 PM	0
4/23/2025	7:45:00 PM	0
4/23/2025	8:00:00 PM	0
4/23/2025	8:15:00 PM	0
4/23/2025	8:30:00 PM	0
4/23/2025	8:45:00 PM	0
4/23/2025	9:00:00 PM	0
4/23/2025	9:15:00 PM	0
4/23/2025	9:30:00 PM	0
4/23/2025	9:45:00 PM	0
4/23/2025	10:00:00 PM	0
4/23/2025	10:15:00 PM	0
4/23/2025	10:30:00 PM	0
4/23/2025	10:45:00 PM	0
4/23/2025	11:00:00 PM	0
4/23/2025	11:15:00 PM	0
4/23/2025	11:30:00 PM	0
4/23/2025	11:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/24/2025	12:00:00 AM	0
4/24/2025	12:15:00 AM	0
4/24/2025	12:30:00 AM	0
4/24/2025	12:45:00 AM	0
4/24/2025	1:00:00 AM	0
4/24/2025	1:15:00 AM	0
4/24/2025	1:30:00 AM	0
4/24/2025	1:45:00 AM	0
4/24/2025	2:00:00 AM	0
4/24/2025	2:15:00 AM	0
4/24/2025	2:30:00 AM	0
4/24/2025	2:45:00 AM	0
4/24/2025	3:00:00 AM	0
4/24/2025	3:15:00 AM	0
4/24/2025	3:30:00 AM	0
4/24/2025	3:45:00 AM	0
4/24/2025	4:00:00 AM	0
4/24/2025	4:15:00 AM	0
4/24/2025	4:30:00 AM	0
4/24/2025	4:45:00 AM	0
4/24/2025	5:00:00 AM	0
4/24/2025	5:15:00 AM	0
4/24/2025	5:30:00 AM	0
4/24/2025	5:45:00 AM	0
4/24/2025	6:00:00 AM	0
4/24/2025	6:15:00 AM	0
4/24/2025	6:30:00 AM	0
4/24/2025	6:45:00 AM	0
4/24/2025	7:00:00 AM	0
4/24/2025	7:15:00 AM	0
4/24/2025	7:30:00 AM	0
4/24/2025	7:45:00 AM	0
4/24/2025	8:00:00 AM	0
4/24/2025	8:15:00 AM	0
4/24/2025	8:30:00 AM	0
4/24/2025	8:45:00 AM	0
4/24/2025	9:00:00 AM	0
4/24/2025	9:15:00 AM	0
4/24/2025	9:30:00 AM	0
4/24/2025	9:45:00 AM	0
4/24/2025	10:00:00 AM	0
4/24/2025	10:15:00 AM	0
4/24/2025	10:30:00 AM	0
4/24/2025	10:45:00 AM	0
4/24/2025	11:00:00 AM	0
4/24/2025	11:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/24/2025	11:30:00 AM	0
4/24/2025	11:45:00 AM	0
4/24/2025	12:00:00 PM	0
4/24/2025	12:15:00 PM	0
4/24/2025	12:30:00 PM	0
4/24/2025	12:45:00 PM	0
4/24/2025	1:00:00 PM	0
4/24/2025	1:15:00 PM	0
4/24/2025	1:30:00 PM	0
4/24/2025	1:45:00 PM	0
4/24/2025	2:00:00 PM	0
4/24/2025	2:15:00 PM	0
4/24/2025	2:30:00 PM	0
4/24/2025	2:45:00 PM	0
4/24/2025	3:00:00 PM	0
4/24/2025	3:15:00 PM	0
4/24/2025	3:30:00 PM	0
4/24/2025	3:45:00 PM	0
4/24/2025	4:00:00 PM	0
4/24/2025	4:15:00 PM	0
4/24/2025	4:30:00 PM	0
4/24/2025	4:45:00 PM	0
4/24/2025	5:00:00 PM	0
4/24/2025	5:15:00 PM	0
4/24/2025	5:30:00 PM	0
4/24/2025	5:45:00 PM	0
4/24/2025	6:00:00 PM	0
4/24/2025	6:15:00 PM	0
4/24/2025	6:30:00 PM	0
4/24/2025	6:45:00 PM	0
4/24/2025	7:00:00 PM	0
4/24/2025	7:15:00 PM	0
4/24/2025	7:30:00 PM	0
4/24/2025	7:45:00 PM	0
4/24/2025	8:00:00 PM	0
4/24/2025	8:15:00 PM	0
4/24/2025	8:30:00 PM	0
4/24/2025	8:45:00 PM	0
4/24/2025	9:00:00 PM	0
4/24/2025	9:15:00 PM	0
4/24/2025	9:30:00 PM	0
4/24/2025	9:45:00 PM	0
4/24/2025	10:00:00 PM	0
4/24/2025	10:15:00 PM	0
4/24/2025	10:30:00 PM	0
4/24/2025	10:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/24/2025	11:00:00 PM	0
4/24/2025	11:15:00 PM	0
4/24/2025	11:30:00 PM	0
4/24/2025	11:45:00 PM	0
4/25/2025	12:00:00 AM	0
4/25/2025	12:15:00 AM	0
4/25/2025	12:30:00 AM	0
4/25/2025	12:45:00 AM	0
4/25/2025	1:00:00 AM	0
4/25/2025	1:15:00 AM	0
4/25/2025	1:30:00 AM	0
4/25/2025	1:45:00 AM	0
4/25/2025	2:00:00 AM	0
4/25/2025	2:15:00 AM	0
4/25/2025	2:30:00 AM	0
4/25/2025	2:45:00 AM	0
4/25/2025	3:00:00 AM	0
4/25/2025	3:15:00 AM	0
4/25/2025	3:30:00 AM	0
4/25/2025	3:45:00 AM	0
4/25/2025	4:00:00 AM	0
4/25/2025	4:15:00 AM	0
4/25/2025	4:30:00 AM	0
4/25/2025	4:45:00 AM	0
4/25/2025	5:00:00 AM	0
4/25/2025	5:15:00 AM	0
4/25/2025	5:30:00 AM	0
4/25/2025	5:45:00 AM	0
4/25/2025	6:00:00 AM	0
4/25/2025	6:15:00 AM	0
4/25/2025	6:30:00 AM	0
4/25/2025	6:45:00 AM	0
4/25/2025	7:00:00 AM	0
4/25/2025	7:15:00 AM	0
4/25/2025	7:30:00 AM	0
4/25/2025	7:45:00 AM	0
4/25/2025	8:00:00 AM	0
4/25/2025	8:15:00 AM	0
4/25/2025	8:30:00 AM	0
4/25/2025	8:45:00 AM	0
4/25/2025	9:00:00 AM	0
4/25/2025	9:15:00 AM	0
4/25/2025	9:30:00 AM	0
4/25/2025	9:45:00 AM	0
4/25/2025	10:00:00 AM	0
4/25/2025	10:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/25/2025	10:30:00 AM	0
4/25/2025	10:45:00 AM	0
4/25/2025	11:00:00 AM	0
4/25/2025	11:15:00 AM	0
4/25/2025	11:30:00 AM	0
4/25/2025	11:45:00 AM	0
4/25/2025	12:00:00 PM	0
4/25/2025	12:15:00 PM	0
4/25/2025	12:30:00 PM	0
4/25/2025	12:45:00 PM	0
4/25/2025	1:00:00 PM	0
4/25/2025	1:15:00 PM	0
4/25/2025	1:30:00 PM	0
4/25/2025	1:45:00 PM	0
4/25/2025	2:00:00 PM	0
4/25/2025	2:15:00 PM	0
4/25/2025	2:30:00 PM	0
4/25/2025	2:45:00 PM	0
4/25/2025	3:00:00 PM	0
4/25/2025	3:15:00 PM	0
4/25/2025	3:30:00 PM	0
4/25/2025	3:45:00 PM	0
4/25/2025	4:00:00 PM	0
4/25/2025	4:15:00 PM	0
4/25/2025	4:30:00 PM	0
4/25/2025	4:45:00 PM	0
4/25/2025	5:00:00 PM	0
4/25/2025	5:15:00 PM	0
4/25/2025	5:30:00 PM	0
4/25/2025	5:45:00 PM	0
4/25/2025	6:00:00 PM	0
4/25/2025	6:15:00 PM	0
4/25/2025	6:30:00 PM	0
4/25/2025	6:45:00 PM	0
4/25/2025	7:00:00 PM	0
4/25/2025	7:15:00 PM	0
4/25/2025	7:30:00 PM	0
4/25/2025	7:45:00 PM	0
4/25/2025	8:00:00 PM	0
4/25/2025	8:15:00 PM	0
4/25/2025	8:30:00 PM	0
4/25/2025	8:45:00 PM	0
4/25/2025	9:00:00 PM	0
4/25/2025	9:15:00 PM	0
4/25/2025	9:30:00 PM	0
4/25/2025	9:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/25/2025	10:00:00 PM	0
4/25/2025	10:15:00 PM	0
4/25/2025	10:30:00 PM	0
4/25/2025	10:45:00 PM	0
4/25/2025	11:00:00 PM	0
4/25/2025	11:15:00 PM	0
4/25/2025	11:30:00 PM	0
4/25/2025	11:45:00 PM	0
4/26/2025	12:00:00 AM	0
4/26/2025	12:15:00 AM	0
4/26/2025	12:30:00 AM	0
4/26/2025	12:45:00 AM	0
4/26/2025	1:00:00 AM	0
4/26/2025	1:15:00 AM	0
4/26/2025	1:30:00 AM	0
4/26/2025	1:45:00 AM	0
4/26/2025	2:00:00 AM	0
4/26/2025	2:15:00 AM	0
4/26/2025	2:30:00 AM	0
4/26/2025	2:45:00 AM	0
4/26/2025	3:00:00 AM	0
4/26/2025	3:15:00 AM	0
4/26/2025	3:30:00 AM	0
4/26/2025	3:45:00 AM	0
4/26/2025	4:00:00 AM	0
4/26/2025	4:15:00 AM	0
4/26/2025	4:30:00 AM	0
4/26/2025	4:45:00 AM	0
4/26/2025	5:00:00 AM	0
4/26/2025	5:15:00 AM	0
4/26/2025	5:30:00 AM	0
4/26/2025	5:45:00 AM	0
4/26/2025	6:00:00 AM	0
4/26/2025	6:15:00 AM	0
4/26/2025	6:30:00 AM	0
4/26/2025	6:45:00 AM	0
4/26/2025	7:00:00 AM	0
4/26/2025	7:15:00 AM	0
4/26/2025	7:30:00 AM	0
4/26/2025	7:45:00 AM	0
4/26/2025	8:00:00 AM	0
4/26/2025	8:15:00 AM	0
4/26/2025	8:30:00 AM	0
4/26/2025	8:45:00 AM	0
4/26/2025	9:00:00 AM	0
4/26/2025	9:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/26/2025	9:30:00 AM	0
4/26/2025	9:45:00 AM	0
4/26/2025	10:00:00 AM	0
4/26/2025	10:15:00 AM	0
4/26/2025	10:30:00 AM	0
4/26/2025	10:45:00 AM	0
4/26/2025	11:00:00 AM	0
4/26/2025	11:15:00 AM	0
4/26/2025	11:30:00 AM	0
4/26/2025	11:45:00 AM	0
4/26/2025	12:00:00 PM	0
4/26/2025	12:15:00 PM	0
4/26/2025	12:30:00 PM	0
4/26/2025	12:45:00 PM	0
4/26/2025	1:00:00 PM	0
4/26/2025	1:15:00 PM	0
4/26/2025	1:30:00 PM	0
4/26/2025	1:45:00 PM	0
4/26/2025	2:00:00 PM	0
4/26/2025	2:15:00 PM	0
4/26/2025	2:30:00 PM	0
4/26/2025	2:45:00 PM	0
4/26/2025	3:00:00 PM	0
4/26/2025	3:15:00 PM	0
4/26/2025	3:30:00 PM	0
4/26/2025	3:45:00 PM	0
4/26/2025	4:00:00 PM	0
4/26/2025	4:15:00 PM	0
4/26/2025	4:30:00 PM	0
4/26/2025	4:45:00 PM	0
4/26/2025	5:00:00 PM	0
4/26/2025	5:15:00 PM	0
4/26/2025	5:30:00 PM	0
4/26/2025	5:45:00 PM	0
4/26/2025	6:00:00 PM	0
4/26/2025	6:15:00 PM	0
4/26/2025	6:30:00 PM	0
4/26/2025	6:45:00 PM	0
4/26/2025	7:00:00 PM	0
4/26/2025	7:15:00 PM	0
4/26/2025	7:30:00 PM	0
4/26/2025	7:45:00 PM	0
4/26/2025	8:00:00 PM	0
4/26/2025	8:15:00 PM	0
4/26/2025	8:30:00 PM	0
4/26/2025	8:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/26/2025	9:00:00 PM	0
4/26/2025	9:15:00 PM	0
4/26/2025	9:30:00 PM	0
4/26/2025	9:45:00 PM	0
4/26/2025	10:00:00 PM	0
4/26/2025	10:15:00 PM	0
4/26/2025	10:30:00 PM	0
4/26/2025	10:45:00 PM	0
4/26/2025	11:00:00 PM	0
4/26/2025	11:15:00 PM	0
4/26/2025	11:30:00 PM	0
4/26/2025	11:45:00 PM	0
4/27/2025	12:00:00 AM	0
4/27/2025	12:15:00 AM	0
4/27/2025	12:30:00 AM	0
4/27/2025	12:45:00 AM	0
4/27/2025	1:00:00 AM	0
4/27/2025	1:15:00 AM	0
4/27/2025	1:30:00 AM	0
4/27/2025	1:45:00 AM	0
4/27/2025	2:00:00 AM	0
4/27/2025	2:15:00 AM	0
4/27/2025	2:30:00 AM	0
4/27/2025	2:45:00 AM	0
4/27/2025	3:00:00 AM	0
4/27/2025	3:15:00 AM	0
4/27/2025	3:30:00 AM	0
4/27/2025	3:45:00 AM	0
4/27/2025	4:00:00 AM	0
4/27/2025	4:15:00 AM	0
4/27/2025	4:30:00 AM	0
4/27/2025	4:45:00 AM	0
4/27/2025	5:00:00 AM	0
4/27/2025	5:15:00 AM	0
4/27/2025	5:30:00 AM	0
4/27/2025	5:45:00 AM	0
4/27/2025	6:00:00 AM	0
4/27/2025	6:15:00 AM	0
4/27/2025	6:30:00 AM	0
4/27/2025	6:45:00 AM	0
4/27/2025	7:00:00 AM	0
4/27/2025	7:15:00 AM	0
4/27/2025	7:30:00 AM	0
4/27/2025	7:45:00 AM	0
4/27/2025	8:00:00 AM	0
4/27/2025	8:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/27/2025	8:30:00 AM	0
4/27/2025	8:45:00 AM	0
4/27/2025	9:00:00 AM	0
4/27/2025	9:15:00 AM	0
4/27/2025	9:30:00 AM	0
4/27/2025	9:45:00 AM	0
4/27/2025	10:00:00 AM	0
4/27/2025	10:15:00 AM	0
4/27/2025	10:30:00 AM	0
4/27/2025	10:45:00 AM	0
4/27/2025	11:00:00 AM	0
4/27/2025	11:15:00 AM	0
4/27/2025	11:30:00 AM	0
4/27/2025	11:45:00 AM	0
4/27/2025	12:00:00 PM	0
4/27/2025	12:15:00 PM	0
4/27/2025	12:30:00 PM	0
4/27/2025	12:45:00 PM	0
4/27/2025	1:00:00 PM	0
4/27/2025	1:15:00 PM	0
4/27/2025	1:30:00 PM	0
4/27/2025	1:45:00 PM	0
4/27/2025	2:00:00 PM	0
4/27/2025	2:15:00 PM	0
4/27/2025	2:30:00 PM	0
4/27/2025	2:45:00 PM	0
4/27/2025	3:00:00 PM	0
4/27/2025	3:15:00 PM	0
4/27/2025	3:30:00 PM	0
4/27/2025	3:45:00 PM	0
4/27/2025	4:00:00 PM	0
4/27/2025	4:15:00 PM	0
4/27/2025	4:30:00 PM	0
4/27/2025	4:45:00 PM	0
4/27/2025	5:00:00 PM	0
4/27/2025	5:15:00 PM	0
4/27/2025	5:30:00 PM	0
4/27/2025	5:45:00 PM	0
4/27/2025	6:00:00 PM	0
4/27/2025	6:15:00 PM	0
4/27/2025	6:30:00 PM	0
4/27/2025	6:45:00 PM	0
4/27/2025	7:00:00 PM	0
4/27/2025	7:15:00 PM	0
4/27/2025	7:30:00 PM	0
4/27/2025	7:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/27/2025	8:00:00 PM	0
4/27/2025	8:15:00 PM	0
4/27/2025	8:30:00 PM	0
4/27/2025	8:45:00 PM	0
4/27/2025	9:00:00 PM	0
4/27/2025	9:15:00 PM	0
4/27/2025	9:30:00 PM	0
4/27/2025	9:45:00 PM	0
4/27/2025	10:00:00 PM	0
4/27/2025	10:15:00 PM	0
4/27/2025	10:30:00 PM	0
4/27/2025	10:45:00 PM	0
4/27/2025	11:00:00 PM	0
4/27/2025	11:15:00 PM	0
4/27/2025	11:30:00 PM	0
4/27/2025	11:45:00 PM	0
4/28/2025	12:00:00 AM	0
4/28/2025	12:15:00 AM	0
4/28/2025	12:30:00 AM	0
4/28/2025	12:45:00 AM	0
4/28/2025	1:00:00 AM	0
4/28/2025	1:15:00 AM	0
4/28/2025	1:30:00 AM	0
4/28/2025	1:45:00 AM	0
4/28/2025	2:00:00 AM	0
4/28/2025	2:15:00 AM	0
4/28/2025	2:30:00 AM	0
4/28/2025	2:45:00 AM	0
4/28/2025	3:00:00 AM	0
4/28/2025	3:15:00 AM	0
4/28/2025	3:30:00 AM	0
4/28/2025	3:45:00 AM	0
4/28/2025	4:00:00 AM	0
4/28/2025	4:15:00 AM	0
4/28/2025	4:30:00 AM	0
4/28/2025	4:45:00 AM	0
4/28/2025	5:00:00 AM	0
4/28/2025	5:15:00 AM	0
4/28/2025	5:30:00 AM	0
4/28/2025	5:45:00 AM	0
4/28/2025	6:00:00 AM	0
4/28/2025	6:15:00 AM	0
4/28/2025	6:30:00 AM	0
4/28/2025	6:45:00 AM	0
4/28/2025	7:00:00 AM	0
4/28/2025	7:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/28/2025	7:30:00 AM	0
4/28/2025	7:45:00 AM	0
4/28/2025	8:00:00 AM	0
4/28/2025	8:15:00 AM	0
4/28/2025	8:30:00 AM	0
4/28/2025	8:45:00 AM	0
4/28/2025	9:00:00 AM	0
4/28/2025	9:15:00 AM	0
4/28/2025	9:30:00 AM	0
4/28/2025	9:45:00 AM	0
4/28/2025	10:00:00 AM	0
4/28/2025	10:15:00 AM	0
4/28/2025	10:30:00 AM	0
4/28/2025	10:45:00 AM	0
4/28/2025	11:00:00 AM	0
4/28/2025	11:15:00 AM	0
4/28/2025	11:30:00 AM	0
4/28/2025	11:45:00 AM	0
4/28/2025	12:00:00 PM	0
4/28/2025	12:15:00 PM	0
4/28/2025	12:30:00 PM	0
4/28/2025	12:45:00 PM	0
4/28/2025	1:00:00 PM	0
4/28/2025	1:15:00 PM	0
4/28/2025	1:30:00 PM	0
4/28/2025	1:45:00 PM	0
4/28/2025	2:00:00 PM	0
4/28/2025	2:15:00 PM	0
4/28/2025	2:30:00 PM	0
4/28/2025	2:45:00 PM	0
4/28/2025	3:00:00 PM	0
4/28/2025	3:15:00 PM	0
4/28/2025	3:30:00 PM	0
4/28/2025	3:45:00 PM	0
4/28/2025	4:00:00 PM	0
4/28/2025	4:15:00 PM	0
4/28/2025	4:30:00 PM	0
4/28/2025	4:45:00 PM	0
4/28/2025	5:00:00 PM	0
4/28/2025	5:15:00 PM	0
4/28/2025	5:30:00 PM	0
4/28/2025	5:45:00 PM	0
4/28/2025	6:00:00 PM	0
4/28/2025	6:15:00 PM	0
4/28/2025	6:30:00 PM	0
4/28/2025	6:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/28/2025	7:00:00 PM	0
4/28/2025	7:15:00 PM	0
4/28/2025	7:30:00 PM	0
4/28/2025	7:45:00 PM	0
4/28/2025	8:00:00 PM	0
4/28/2025	8:15:00 PM	0
4/28/2025	8:30:00 PM	0
4/28/2025	8:45:00 PM	0
4/28/2025	9:00:00 PM	0
4/28/2025	9:15:00 PM	0
4/28/2025	9:30:00 PM	0
4/28/2025	9:45:00 PM	0
4/28/2025	10:00:00 PM	0
4/28/2025	10:15:00 PM	0
4/28/2025	10:30:00 PM	0
4/28/2025	10:45:00 PM	0
4/28/2025	11:00:00 PM	0
4/28/2025	11:15:00 PM	0
4/28/2025	11:30:00 PM	0
4/28/2025	11:45:00 PM	0
4/29/2025	12:00:00 AM	0
4/29/2025	12:15:00 AM	0
4/29/2025	12:30:00 AM	0
4/29/2025	12:45:00 AM	0
4/29/2025	1:00:00 AM	0
4/29/2025	1:15:00 AM	0
4/29/2025	1:30:00 AM	0
4/29/2025	1:45:00 AM	0
4/29/2025	2:00:00 AM	0
4/29/2025	2:15:00 AM	0
4/29/2025	2:30:00 AM	0
4/29/2025	2:45:00 AM	0
4/29/2025	3:00:00 AM	0
4/29/2025	3:15:00 AM	0
4/29/2025	3:30:00 AM	0
4/29/2025	3:45:00 AM	0
4/29/2025	4:00:00 AM	0
4/29/2025	4:15:00 AM	0
4/29/2025	4:30:00 AM	0
4/29/2025	4:45:00 AM	0
4/29/2025	5:00:00 AM	0
4/29/2025	5:15:00 AM	0
4/29/2025	5:30:00 AM	0
4/29/2025	5:45:00 AM	0
4/29/2025	6:00:00 AM	0
4/29/2025	6:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/29/2025	6:30:00 AM	0
4/29/2025	6:45:00 AM	0
4/29/2025	7:00:00 AM	0
4/29/2025	7:15:00 AM	0
4/29/2025	7:30:00 AM	0
4/29/2025	7:45:00 AM	0
4/29/2025	8:00:00 AM	0
4/29/2025	8:15:00 AM	0
4/29/2025	8:30:00 AM	0
4/29/2025	8:45:00 AM	0
4/29/2025	9:00:00 AM	0
4/29/2025	9:15:00 AM	0
4/29/2025	9:30:00 AM	0
4/29/2025	9:45:00 AM	0
4/29/2025	10:00:00 AM	0
4/29/2025	10:15:00 AM	0
4/29/2025	10:30:00 AM	0
4/29/2025	10:45:00 AM	0
4/29/2025	11:00:00 AM	0
4/29/2025	11:15:00 AM	0
4/29/2025	11:30:00 AM	0
4/29/2025	11:45:00 AM	0
4/29/2025	12:00:00 PM	0
4/29/2025	12:15:00 PM	0
4/29/2025	12:30:00 PM	0
4/29/2025	12:45:00 PM	0
4/29/2025	1:00:00 PM	0
4/29/2025	1:15:00 PM	0
4/29/2025	1:30:00 PM	0
4/29/2025	1:45:00 PM	0
4/29/2025	2:00:00 PM	0
4/29/2025	2:15:00 PM	0
4/29/2025	2:30:00 PM	0
4/29/2025	2:45:00 PM	0
4/29/2025	3:00:00 PM	0
4/29/2025	3:15:00 PM	0
4/29/2025	3:30:00 PM	0
4/29/2025	3:45:00 PM	0
4/29/2025	4:00:00 PM	0
4/29/2025	4:15:00 PM	0
4/29/2025	4:30:00 PM	0
4/29/2025	4:45:00 PM	0
4/29/2025	5:00:00 PM	0
4/29/2025	5:15:00 PM	0
4/29/2025	5:30:00 PM	0
4/29/2025	5:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/29/2025	6:00:00 PM	0
4/29/2025	6:15:00 PM	0
4/29/2025	6:30:00 PM	0
4/29/2025	6:45:00 PM	0
4/29/2025	7:00:00 PM	0
4/29/2025	7:15:00 PM	0
4/29/2025	7:30:00 PM	0
4/29/2025	7:45:00 PM	0
4/29/2025	8:00:00 PM	0
4/29/2025	8:15:00 PM	0
4/29/2025	8:30:00 PM	0
4/29/2025	8:45:00 PM	0
4/29/2025	9:00:00 PM	0
4/29/2025	9:15:00 PM	0
4/29/2025	9:30:00 PM	0
4/29/2025	9:45:00 PM	0
4/29/2025	10:00:00 PM	0
4/29/2025	10:15:00 PM	0
4/29/2025	10:30:00 PM	0
4/29/2025	10:45:00 PM	0
4/29/2025	11:00:00 PM	0
4/29/2025	11:15:00 PM	0
4/29/2025	11:30:00 PM	0
4/29/2025	11:45:00 PM	0
4/30/2025	12:00:00 AM	0
4/30/2025	12:15:00 AM	0
4/30/2025	12:30:00 AM	0
4/30/2025	12:45:00 AM	0
4/30/2025	1:00:00 AM	0
4/30/2025	1:15:00 AM	0
4/30/2025	1:30:00 AM	0
4/30/2025	1:45:00 AM	0
4/30/2025	2:00:00 AM	0
4/30/2025	2:15:00 AM	0
4/30/2025	2:30:00 AM	0
4/30/2025	2:45:00 AM	0
4/30/2025	3:00:00 AM	0
4/30/2025	3:15:00 AM	0
4/30/2025	3:30:00 AM	0
4/30/2025	3:45:00 AM	0
4/30/2025	4:00:00 AM	0
4/30/2025	4:15:00 AM	0
4/30/2025	4:30:00 AM	0
4/30/2025	4:45:00 AM	0
4/30/2025	5:00:00 AM	0
4/30/2025	5:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/30/2025	5:30:00 AM	0
4/30/2025	5:45:00 AM	0
4/30/2025	6:00:00 AM	0
4/30/2025	6:15:00 AM	0
4/30/2025	6:30:00 AM	0
4/30/2025	6:45:00 AM	0
4/30/2025	7:00:00 AM	0
4/30/2025	7:15:00 AM	0
4/30/2025	7:30:00 AM	0
4/30/2025	7:45:00 AM	0
4/30/2025	8:00:00 AM	0
4/30/2025	8:15:00 AM	0
4/30/2025	8:30:00 AM	0
4/30/2025	8:45:00 AM	0
4/30/2025	9:00:00 AM	0
4/30/2025	9:15:00 AM	0
4/30/2025	9:30:00 AM	0
4/30/2025	9:45:00 AM	0
4/30/2025	10:00:00 AM	0
4/30/2025	10:15:00 AM	0
4/30/2025	10:30:00 AM	0
4/30/2025	10:45:00 AM	0
4/30/2025	11:00:00 AM	0
4/30/2025	11:15:00 AM	0
4/30/2025	11:30:00 AM	0
4/30/2025	11:45:00 AM	0
4/30/2025	12:00:00 PM	0
4/30/2025	12:15:00 PM	0
4/30/2025	12:30:00 PM	0
4/30/2025	12:45:00 PM	0
4/30/2025	1:00:00 PM	0
4/30/2025	1:15:00 PM	0
4/30/2025	1:30:00 PM	0
4/30/2025	1:45:00 PM	0
4/30/2025	2:00:00 PM	0
4/30/2025	2:15:00 PM	0
4/30/2025	2:30:00 PM	0
4/30/2025	2:45:00 PM	0
4/30/2025	3:00:00 PM	0
4/30/2025	3:15:00 PM	0
4/30/2025	3:30:00 PM	0
4/30/2025	3:45:00 PM	0
4/30/2025	4:00:00 PM	0
4/30/2025	4:15:00 PM	0
4/30/2025	4:30:00 PM	0
4/30/2025	4:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
4/30/2025	5:00:00 PM	0
4/30/2025	5:15:00 PM	0
4/30/2025	5:30:00 PM	0
4/30/2025	5:45:00 PM	0
4/30/2025	6:00:00 PM	0
4/30/2025	6:15:00 PM	0
4/30/2025	6:30:00 PM	0
4/30/2025	6:45:00 PM	0
4/30/2025	7:00:00 PM	0
4/30/2025	7:15:00 PM	0
4/30/2025	7:30:00 PM	0
4/30/2025	7:45:00 PM	0
4/30/2025	8:00:00 PM	0
4/30/2025	8:15:00 PM	0
4/30/2025	8:30:00 PM	0
4/30/2025	8:45:00 PM	0
4/30/2025	9:00:00 PM	0
4/30/2025	9:15:00 PM	0
4/30/2025	9:30:00 PM	0
4/30/2025	9:45:00 PM	0
4/30/2025	10:00:00 PM	0
4/30/2025	10:15:00 PM	0
4/30/2025	10:30:00 PM	0
4/30/2025	10:45:00 PM	0
4/30/2025	11:00:00 PM	0
4/30/2025	11:15:00 PM	0
4/30/2025	11:30:00 PM	0
4/30/2025	11:45:00 PM	0

Georges Ditch Return

Station 0217

Date	Flow (cfs)
4/1/2025	0.38
4/2/2025	0.34
4/3/2025	0.61
4/4/2025	0.54
4/5/2025	0.49
4/6/2025	0.47
4/7/2025	0.50
4/8/2025	0.62
4/9/2025	0.49
4/10/2025	0.36
4/11/2025	0.31
4/12/2025	0.30
4/13/2025	0.26
4/14/2025	0.25
4/15/2025	0.22
4/16/2025	0.22
4/17/2025	0.14
4/18/2025	0.12
4/19/2025	0.20
4/20/2025	0.26
4/21/2025	0.27
4/22/2025	0.22
4/23/2025	0.35
4/24/2025	0.37
4/25/2025	0.34
4/26/2025	0.20
4/27/2025	0.13
4/28/2025	0.22
4/29/2025	0.30
4/30/2025	0.18

Georges Ditch Return Gage

DATE	TIME	GAGE
4/1/2025	12:00:00 AM	0.09
4/1/2025	12:15:00 AM	0.09
4/1/2025	12:30:00 AM	0.09
4/1/2025	12:45:00 AM	0.09
4/1/2025	1:00:00 AM	0.09
4/1/2025	1:15:00 AM	0.09
4/1/2025	1:30:00 AM	0.09
4/1/2025	1:45:00 AM	0.09
4/1/2025	2:00:00 AM	0.08
4/1/2025	2:15:00 AM	0.08
4/1/2025	2:30:00 AM	0.08
4/1/2025	2:45:00 AM	0.08
4/1/2025	3:00:00 AM	0.08
4/1/2025	3:15:00 AM	0.08
4/1/2025	3:30:00 AM	0.08
4/1/2025	3:45:00 AM	0.08
4/1/2025	4:00:00 AM	0.08
4/1/2025	4:15:00 AM	0.08
4/1/2025	4:30:00 AM	0.08
4/1/2025	4:45:00 AM	0.08
4/1/2025	5:00:00 AM	0.08
4/1/2025	5:15:00 AM	0.08
4/1/2025	5:30:00 AM	0.08
4/1/2025	5:45:00 AM	0.08
4/1/2025	6:00:00 AM	0.08
4/1/2025	6:15:00 AM	0.08
4/1/2025	6:30:00 AM	0.08
4/1/2025	6:45:00 AM	0.07
4/1/2025	7:00:00 AM	0.07
4/1/2025	7:15:00 AM	0.08
4/1/2025	7:30:00 AM	0.08
4/1/2025	7:45:00 AM	0.08
4/1/2025	8:00:00 AM	0.08
4/1/2025	8:15:00 AM	0.08
4/1/2025	8:30:00 AM	0.08
4/1/2025	8:45:00 AM	0.08
4/1/2025	9:00:00 AM	0.08
4/1/2025	9:15:00 AM	0.08
4/1/2025	9:30:00 AM	0.08
4/1/2025	9:45:00 AM	0.08
4/1/2025	10:00:00 AM	0.08
4/1/2025	10:15:00 AM	0.08
4/1/2025	10:30:00 AM	0.08
4/1/2025	10:45:00 AM	0.08
4/1/2025	11:00:00 AM	0.08
4/1/2025	11:15:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
4/1/2025	11:30:00 AM	0.07
4/1/2025	11:45:00 AM	0.07
4/1/2025	12:00:00 PM	0.07
4/1/2025	12:15:00 PM	0.07
4/1/2025	12:30:00 PM	0.07
4/1/2025	12:45:00 PM	0.07
4/1/2025	1:00:00 PM	0.08
4/1/2025	1:15:00 PM	0.08
4/1/2025	1:30:00 PM	0.08
4/1/2025	1:45:00 PM	0.08
4/1/2025	2:00:00 PM	0.08
4/1/2025	2:15:00 PM	0.08
4/1/2025	2:30:00 PM	0.08
4/1/2025	2:45:00 PM	0.08
4/1/2025	3:00:00 PM	0.08
4/1/2025	3:15:00 PM	0.08
4/1/2025	3:30:00 PM	0.08
4/1/2025	3:45:00 PM	0.08
4/1/2025	4:00:00 PM	0.08
4/1/2025	4:15:00 PM	0.08
4/1/2025	4:30:00 PM	0.08
4/1/2025	4:45:00 PM	0.08
4/1/2025	5:00:00 PM	0.08
4/1/2025	5:15:00 PM	0.08
4/1/2025	5:30:00 PM	0.08
4/1/2025	5:45:00 PM	0.08
4/1/2025	6:00:00 PM	0.08
4/1/2025	6:15:00 PM	0.08
4/1/2025	6:30:00 PM	0.08
4/1/2025	6:45:00 PM	0.08
4/1/2025	7:00:00 PM	0.08
4/1/2025	7:15:00 PM	0.08
4/1/2025	7:30:00 PM	0.08
4/1/2025	7:45:00 PM	0.08
4/1/2025	8:00:00 PM	0.08
4/1/2025	8:15:00 PM	0.08
4/1/2025	8:30:00 PM	0.08
4/1/2025	8:45:00 PM	0.08
4/1/2025	9:00:00 PM	0.08
4/1/2025	9:15:00 PM	0.08
4/1/2025	9:30:00 PM	0.08
4/1/2025	9:45:00 PM	0.08
4/1/2025	10:00:00 PM	0.08
4/1/2025	10:15:00 PM	0.08
4/1/2025	10:30:00 PM	0.08
4/1/2025	10:45:00 PM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
4/1/2025	11:00:00 PM	0.08
4/1/2025	11:15:00 PM	0.08
4/1/2025	11:30:00 PM	0.08
4/1/2025	11:45:00 PM	0.08
4/2/2025	12:00:00 AM	0.08
4/2/2025	12:15:00 AM	0.08
4/2/2025	12:30:00 AM	0.08
4/2/2025	12:45:00 AM	0.08
4/2/2025	1:00:00 AM	0.07
4/2/2025	1:15:00 AM	0.07
4/2/2025	1:30:00 AM	0.07
4/2/2025	1:45:00 AM	0.07
4/2/2025	2:00:00 AM	0.07
4/2/2025	2:15:00 AM	0.07
4/2/2025	2:30:00 AM	0.07
4/2/2025	2:45:00 AM	0.06
4/2/2025	3:00:00 AM	0.06
4/2/2025	3:15:00 AM	0.06
4/2/2025	3:30:00 AM	0.06
4/2/2025	3:45:00 AM	0.07
4/2/2025	4:00:00 AM	0.07
4/2/2025	4:15:00 AM	0.07
4/2/2025	4:30:00 AM	0.07
4/2/2025	4:45:00 AM	0.07
4/2/2025	5:00:00 AM	0.07
4/2/2025	5:15:00 AM	0.07
4/2/2025	5:30:00 AM	0.07
4/2/2025	5:45:00 AM	0.07
4/2/2025	6:00:00 AM	0.07
4/2/2025	6:15:00 AM	0.07
4/2/2025	6:30:00 AM	0.07
4/2/2025	6:45:00 AM	0.07
4/2/2025	7:00:00 AM	0.07
4/2/2025	7:15:00 AM	0.07
4/2/2025	7:30:00 AM	0.07
4/2/2025	7:45:00 AM	0.07
4/2/2025	8:00:00 AM	0.07
4/2/2025	8:15:00 AM	0.06
4/2/2025	8:30:00 AM	0.06
4/2/2025	8:45:00 AM	0.06
4/2/2025	9:00:00 AM	0.06
4/2/2025	9:15:00 AM	0.06
4/2/2025	9:30:00 AM	0.06
4/2/2025	9:45:00 AM	0.06
4/2/2025	10:00:00 AM	0.06
4/2/2025	10:15:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
4/2/2025	10:30:00 AM	0.06
4/2/2025	10:45:00 AM	0.06
4/2/2025	11:00:00 AM	0.06
4/2/2025	11:15:00 AM	0.06
4/2/2025	11:30:00 AM	0.06
4/2/2025	11:45:00 AM	0.06
4/2/2025	12:00:00 PM	0.06
4/2/2025	12:15:00 PM	0.06
4/2/2025	12:30:00 PM	0.06
4/2/2025	12:45:00 PM	0.06
4/2/2025	1:00:00 PM	0.06
4/2/2025	1:15:00 PM	0.06
4/2/2025	1:30:00 PM	0.06
4/2/2025	1:45:00 PM	0.06
4/2/2025	2:00:00 PM	0.07
4/2/2025	2:15:00 PM	0.07
4/2/2025	2:30:00 PM	0.07
4/2/2025	2:45:00 PM	0.07
4/2/2025	3:00:00 PM	0.07
4/2/2025	3:15:00 PM	0.07
4/2/2025	3:30:00 PM	0.07
4/2/2025	3:45:00 PM	0.07
4/2/2025	4:00:00 PM	0.07
4/2/2025	4:15:00 PM	0.07
4/2/2025	4:30:00 PM	0.07
4/2/2025	4:45:00 PM	0.07
4/2/2025	5:00:00 PM	0.07
4/2/2025	5:15:00 PM	0.07
4/2/2025	5:30:00 PM	0.07
4/2/2025	5:45:00 PM	0.07
4/2/2025	6:00:00 PM	0.07
4/2/2025	6:15:00 PM	0.07
4/2/2025	6:30:00 PM	0.07
4/2/2025	6:45:00 PM	0.07
4/2/2025	7:00:00 PM	0.08
4/2/2025	7:15:00 PM	0.08
4/2/2025	7:30:00 PM	0.08
4/2/2025	7:45:00 PM	0.09
4/2/2025	8:00:00 PM	0.09
4/2/2025	8:15:00 PM	0.09
4/2/2025	8:30:00 PM	0.1
4/2/2025	8:45:00 PM	0.1
4/2/2025	9:00:00 PM	0.1
4/2/2025	9:15:00 PM	0.1
4/2/2025	9:30:00 PM	0.1
4/2/2025	9:45:00 PM	0.11

Georges Ditch Return Gage

DATE	TIME	GAGE
4/2/2025	10:00:00 PM	0.11
4/2/2025	10:15:00 PM	0.11
4/2/2025	10:30:00 PM	0.11
4/2/2025	10:45:00 PM	0.11
4/2/2025	11:00:00 PM	0.11
4/2/2025	11:15:00 PM	0.11
4/2/2025	11:30:00 PM	0.11
4/2/2025	11:45:00 PM	0.11
4/3/2025	12:00:00 AM	0.11
4/3/2025	12:15:00 AM	0.11
4/3/2025	12:30:00 AM	0.11
4/3/2025	12:45:00 AM	0.11
4/3/2025	1:00:00 AM	0.11
4/3/2025	1:15:00 AM	0.11
4/3/2025	1:30:00 AM	0.11
4/3/2025	1:45:00 AM	0.11
4/3/2025	2:00:00 AM	0.11
4/3/2025	2:15:00 AM	0.11
4/3/2025	2:30:00 AM	0.11
4/3/2025	2:45:00 AM	0.11
4/3/2025	3:00:00 AM	0.11
4/3/2025	3:15:00 AM	0.11
4/3/2025	3:30:00 AM	0.11
4/3/2025	3:45:00 AM	0.11
4/3/2025	4:00:00 AM	0.11
4/3/2025	4:15:00 AM	0.11
4/3/2025	4:30:00 AM	0.11
4/3/2025	4:45:00 AM	0.11
4/3/2025	5:00:00 AM	0.11
4/3/2025	5:15:00 AM	0.11
4/3/2025	5:30:00 AM	0.11
4/3/2025	5:45:00 AM	0.11
4/3/2025	6:00:00 AM	0.11
4/3/2025	6:15:00 AM	0.11
4/3/2025	6:30:00 AM	0.11
4/3/2025	6:45:00 AM	0.1
4/3/2025	7:00:00 AM	0.1
4/3/2025	7:15:00 AM	0.1
4/3/2025	7:30:00 AM	0.11
4/3/2025	7:45:00 AM	0.11
4/3/2025	8:00:00 AM	0.11
4/3/2025	8:15:00 AM	0.11
4/3/2025	8:30:00 AM	0.11
4/3/2025	8:45:00 AM	0.11
4/3/2025	9:00:00 AM	0.1
4/3/2025	9:15:00 AM	0.1

Georges Ditch Return Gage

DATE	TIME	GAGE
4/3/2025	9:30:00 AM	0.11
4/3/2025	9:45:00 AM	0.11
4/3/2025	10:00:00 AM	0.11
4/3/2025	10:15:00 AM	0.11
4/3/2025	10:30:00 AM	0.11
4/3/2025	10:45:00 AM	0.11
4/3/2025	11:00:00 AM	0.11
4/3/2025	11:15:00 AM	0.11
4/3/2025	11:30:00 AM	0.11
4/3/2025	11:45:00 AM	0.11
4/3/2025	12:00:00 PM	0.11
4/3/2025	12:15:00 PM	0.11
4/3/2025	12:30:00 PM	0.11
4/3/2025	12:45:00 PM	0.11
4/3/2025	1:00:00 PM	0.11
4/3/2025	1:15:00 PM	0.11
4/3/2025	1:30:00 PM	0.11
4/3/2025	1:45:00 PM	0.11
4/3/2025	2:00:00 PM	0.11
4/3/2025	2:15:00 PM	0.11
4/3/2025	2:30:00 PM	0.11
4/3/2025	2:45:00 PM	0.11
4/3/2025	3:00:00 PM	0.11
4/3/2025	3:15:00 PM	0.11
4/3/2025	3:30:00 PM	0.11
4/3/2025	3:45:00 PM	0.11
4/3/2025	4:00:00 PM	0.11
4/3/2025	4:15:00 PM	0.11
4/3/2025	4:30:00 PM	0.11
4/3/2025	4:45:00 PM	0.11
4/3/2025	5:00:00 PM	0.11
4/3/2025	5:15:00 PM	0.11
4/3/2025	5:30:00 PM	0.11
4/3/2025	5:45:00 PM	0.11
4/3/2025	6:00:00 PM	0.11
4/3/2025	6:15:00 PM	0.11
4/3/2025	6:30:00 PM	0.11
4/3/2025	6:45:00 PM	0.11
4/3/2025	7:00:00 PM	0.11
4/3/2025	7:15:00 PM	0.11
4/3/2025	7:30:00 PM	0.11
4/3/2025	7:45:00 PM	0.11
4/3/2025	8:00:00 PM	0.11
4/3/2025	8:15:00 PM	0.11
4/3/2025	8:30:00 PM	0.11
4/3/2025	8:45:00 PM	0.11

Georges Ditch Return Gage

DATE	TIME	GAGE
4/3/2025	9:00:00 PM	0.11
4/3/2025	9:15:00 PM	0.11
4/3/2025	9:30:00 PM	0.11
4/3/2025	9:45:00 PM	0.11
4/3/2025	10:00:00 PM	0.11
4/3/2025	10:15:00 PM	0.11
4/3/2025	10:30:00 PM	0.11
4/3/2025	10:45:00 PM	0.11
4/3/2025	11:00:00 PM	0.11
4/3/2025	11:15:00 PM	0.11
4/3/2025	11:30:00 PM	0.11
4/3/2025	11:45:00 PM	0.11
4/4/2025	12:00:00 AM	0.11
4/4/2025	12:15:00 AM	0.11
4/4/2025	12:30:00 AM	0.11
4/4/2025	12:45:00 AM	0.11
4/4/2025	1:00:00 AM	0.11
4/4/2025	1:15:00 AM	0.11
4/4/2025	1:30:00 AM	0.11
4/4/2025	1:45:00 AM	0.1
4/4/2025	2:00:00 AM	0.1
4/4/2025	2:15:00 AM	0.11
4/4/2025	2:30:00 AM	0.11
4/4/2025	2:45:00 AM	0.11
4/4/2025	3:00:00 AM	0.11
4/4/2025	3:15:00 AM	0.11
4/4/2025	3:30:00 AM	0.11
4/4/2025	3:45:00 AM	0.11
4/4/2025	4:00:00 AM	0.1
4/4/2025	4:15:00 AM	0.1
4/4/2025	4:30:00 AM	0.1
4/4/2025	4:45:00 AM	0.1
4/4/2025	5:00:00 AM	0.1
4/4/2025	5:15:00 AM	0.1
4/4/2025	5:30:00 AM	0.1
4/4/2025	5:45:00 AM	0.1
4/4/2025	6:00:00 AM	0.1
4/4/2025	6:15:00 AM	0.1
4/4/2025	6:30:00 AM	0.1
4/4/2025	6:45:00 AM	0.1
4/4/2025	7:00:00 AM	0.1
4/4/2025	7:15:00 AM	0.1
4/4/2025	7:30:00 AM	0.1
4/4/2025	7:45:00 AM	0.1
4/4/2025	8:00:00 AM	0.1
4/4/2025	8:15:00 AM	0.1

Georges Ditch Return Gage

DATE	TIME	GAGE
4/4/2025	8:30:00 AM	0.1
4/4/2025	8:45:00 AM	0.1
4/4/2025	9:00:00 AM	0.1
4/4/2025	9:15:00 AM	0.1
4/4/2025	9:30:00 AM	0.09
4/4/2025	9:45:00 AM	0.09
4/4/2025	10:00:00 AM	0.09
4/4/2025	10:15:00 AM	0.09
4/4/2025	10:30:00 AM	0.09
4/4/2025	10:45:00 AM	0.09
4/4/2025	11:00:00 AM	0.09
4/4/2025	11:15:00 AM	0.09
4/4/2025	11:30:00 AM	0.1
4/4/2025	11:45:00 AM	0.1
4/4/2025	12:00:00 PM	0.1
4/4/2025	12:15:00 PM	0.1
4/4/2025	12:30:00 PM	0.1
4/4/2025	12:45:00 PM	0.1
4/4/2025	1:00:00 PM	0.1
4/4/2025	1:15:00 PM	0.1
4/4/2025	1:30:00 PM	0.1
4/4/2025	1:45:00 PM	0.1
4/4/2025	2:00:00 PM	0.1
4/4/2025	2:15:00 PM	0.1
4/4/2025	2:30:00 PM	0.1
4/4/2025	2:45:00 PM	0.1
4/4/2025	3:00:00 PM	0.1
4/4/2025	3:15:00 PM	0.1
4/4/2025	3:30:00 PM	0.1
4/4/2025	3:45:00 PM	0.1
4/4/2025	4:00:00 PM	0.1
4/4/2025	4:15:00 PM	0.1
4/4/2025	4:30:00 PM	0.1
4/4/2025	4:45:00 PM	0.1
4/4/2025	5:00:00 PM	0.1
4/4/2025	5:15:00 PM	0.1
4/4/2025	5:30:00 PM	0.1
4/4/2025	5:45:00 PM	0.1
4/4/2025	6:00:00 PM	0.1
4/4/2025	6:15:00 PM	0.1
4/4/2025	6:30:00 PM	0.1
4/4/2025	6:45:00 PM	0.1
4/4/2025	7:00:00 PM	0.1
4/4/2025	7:15:00 PM	0.1
4/4/2025	7:30:00 PM	0.1
4/4/2025	7:45:00 PM	0.1

Georges Ditch Return Gage

DATE	TIME	GAGE
4/4/2025	8:00:00 PM	0.1
4/4/2025	8:15:00 PM	0.1
4/4/2025	8:30:00 PM	0.1
4/4/2025	8:45:00 PM	0.1
4/4/2025	9:00:00 PM	0.1
4/4/2025	9:15:00 PM	0.1
4/4/2025	9:30:00 PM	0.1
4/4/2025	9:45:00 PM	0.1
4/4/2025	10:00:00 PM	0.1
4/4/2025	10:15:00 PM	0.1
4/4/2025	10:30:00 PM	0.1
4/4/2025	10:45:00 PM	0.1
4/4/2025	11:00:00 PM	0.1
4/4/2025	11:15:00 PM	0.1
4/4/2025	11:30:00 PM	0.1
4/4/2025	11:45:00 PM	0.1
4/5/2025	12:00:00 AM	0.1
4/5/2025	12:15:00 AM	0.1
4/5/2025	12:30:00 AM	0.1
4/5/2025	12:45:00 AM	0.1
4/5/2025	1:00:00 AM	0.1
4/5/2025	1:15:00 AM	0.1
4/5/2025	1:30:00 AM	0.1
4/5/2025	1:45:00 AM	0.1
4/5/2025	2:00:00 AM	0.1
4/5/2025	2:15:00 AM	0.1
4/5/2025	2:30:00 AM	0.1
4/5/2025	2:45:00 AM	0.09
4/5/2025	3:00:00 AM	0.09
4/5/2025	3:15:00 AM	0.09
4/5/2025	3:30:00 AM	0.1
4/5/2025	3:45:00 AM	0.09
4/5/2025	4:00:00 AM	0.09
4/5/2025	4:15:00 AM	0.09
4/5/2025	4:30:00 AM	0.09
4/5/2025	4:45:00 AM	0.1
4/5/2025	5:00:00 AM	0.1
4/5/2025	5:15:00 AM	0.1
4/5/2025	5:30:00 AM	0.1
4/5/2025	5:45:00 AM	0.1
4/5/2025	6:00:00 AM	0.1
4/5/2025	6:15:00 AM	0.1
4/5/2025	6:30:00 AM	0.1
4/5/2025	6:45:00 AM	0.09
4/5/2025	7:00:00 AM	0.09
4/5/2025	7:15:00 AM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
4/5/2025	7:30:00 AM	0.09
4/5/2025	7:45:00 AM	0.09
4/5/2025	8:00:00 AM	0.09
4/5/2025	8:15:00 AM	0.09
4/5/2025	8:30:00 AM	0.09
4/5/2025	8:45:00 AM	0.09
4/5/2025	9:00:00 AM	0.09
4/5/2025	9:15:00 AM	0.09
4/5/2025	9:30:00 AM	0.08
4/5/2025	9:45:00 AM	0.08
4/5/2025	10:00:00 AM	0.08
4/5/2025	10:15:00 AM	0.08
4/5/2025	10:30:00 AM	0.08
4/5/2025	10:45:00 AM	0.08
4/5/2025	11:00:00 AM	0.09
4/5/2025	11:15:00 AM	0.09
4/5/2025	11:30:00 AM	0.09
4/5/2025	11:45:00 AM	0.09
4/5/2025	12:00:00 PM	0.09
4/5/2025	12:15:00 PM	0.09
4/5/2025	12:30:00 PM	0.09
4/5/2025	12:45:00 PM	0.09
4/5/2025	1:00:00 PM	0.09
4/5/2025	1:15:00 PM	0.1
4/5/2025	1:30:00 PM	0.09
4/5/2025	1:45:00 PM	0.09
4/5/2025	2:00:00 PM	0.09
4/5/2025	2:15:00 PM	0.09
4/5/2025	2:30:00 PM	0.09
4/5/2025	2:45:00 PM	0.09
4/5/2025	3:00:00 PM	0.09
4/5/2025	3:15:00 PM	0.09
4/5/2025	3:30:00 PM	0.09
4/5/2025	3:45:00 PM	0.09
4/5/2025	4:00:00 PM	0.09
4/5/2025	4:15:00 PM	0.09
4/5/2025	4:30:00 PM	0.09
4/5/2025	4:45:00 PM	0.09
4/5/2025	5:00:00 PM	0.09
4/5/2025	5:15:00 PM	0.09
4/5/2025	5:30:00 PM	0.1
4/5/2025	5:45:00 PM	0.1
4/5/2025	6:00:00 PM	0.1
4/5/2025	6:15:00 PM	0.1
4/5/2025	6:30:00 PM	0.1
4/5/2025	6:45:00 PM	0.1

Georges Ditch Return Gage

DATE	TIME	GAGE
4/5/2025	7:00:00 PM	0.1
4/5/2025	7:15:00 PM	0.1
4/5/2025	7:30:00 PM	0.1
4/5/2025	7:45:00 PM	0.1
4/5/2025	8:00:00 PM	0.1
4/5/2025	8:15:00 PM	0.1
4/5/2025	8:30:00 PM	0.1
4/5/2025	8:45:00 PM	0.1
4/5/2025	9:00:00 PM	0.1
4/5/2025	9:15:00 PM	0.1
4/5/2025	9:30:00 PM	0.1
4/5/2025	9:45:00 PM	0.1
4/5/2025	10:00:00 PM	0.1
4/5/2025	10:15:00 PM	0.1
4/5/2025	10:30:00 PM	0.1
4/5/2025	10:45:00 PM	0.1
4/5/2025	11:00:00 PM	0.1
4/5/2025	11:15:00 PM	0.1
4/5/2025	11:30:00 PM	0.1
4/5/2025	11:45:00 PM	0.1
4/6/2025	12:00:00 AM	0.1
4/6/2025	12:15:00 AM	0.1
4/6/2025	12:30:00 AM	0.1
4/6/2025	12:45:00 AM	0.1
4/6/2025	1:00:00 AM	0.1
4/6/2025	1:15:00 AM	0.1
4/6/2025	1:30:00 AM	0.1
4/6/2025	1:45:00 AM	0.1
4/6/2025	2:00:00 AM	0.1
4/6/2025	2:15:00 AM	0.1
4/6/2025	2:30:00 AM	0.1
4/6/2025	2:45:00 AM	0.1
4/6/2025	3:00:00 AM	0.1
4/6/2025	3:15:00 AM	0.1
4/6/2025	3:30:00 AM	0.1
4/6/2025	3:45:00 AM	0.1
4/6/2025	4:00:00 AM	0.1
4/6/2025	4:15:00 AM	0.1
4/6/2025	4:30:00 AM	0.1
4/6/2025	4:45:00 AM	0.1
4/6/2025	5:00:00 AM	0.1
4/6/2025	5:15:00 AM	0.1
4/6/2025	5:30:00 AM	0.1
4/6/2025	5:45:00 AM	0.1
4/6/2025	6:00:00 AM	0.1
4/6/2025	6:15:00 AM	0.1

Georges Ditch Return Gage

DATE	TIME	GAGE
4/6/2025	6:30:00 AM	0.1
4/6/2025	6:45:00 AM	0.1
4/6/2025	7:00:00 AM	0.1
4/6/2025	7:15:00 AM	0.1
4/6/2025	7:30:00 AM	0.1
4/6/2025	7:45:00 AM	0.1
4/6/2025	8:00:00 AM	0.1
4/6/2025	8:15:00 AM	0.1
4/6/2025	8:30:00 AM	0.1
4/6/2025	8:45:00 AM	0.1
4/6/2025	9:00:00 AM	0.1
4/6/2025	9:15:00 AM	0.1
4/6/2025	9:30:00 AM	0.09
4/6/2025	9:45:00 AM	0.09
4/6/2025	10:00:00 AM	0.09
4/6/2025	10:15:00 AM	0.09
4/6/2025	10:30:00 AM	0.09
4/6/2025	10:45:00 AM	0.09
4/6/2025	11:00:00 AM	0.08
4/6/2025	11:15:00 AM	0.08
4/6/2025	11:30:00 AM	0.08
4/6/2025	11:45:00 AM	0.08
4/6/2025	12:00:00 PM	0.08
4/6/2025	12:15:00 PM	0.08
4/6/2025	12:30:00 PM	0.08
4/6/2025	12:45:00 PM	0.08
4/6/2025	1:00:00 PM	0.08
4/6/2025	1:15:00 PM	0.08
4/6/2025	1:30:00 PM	0.08
4/6/2025	1:45:00 PM	0.08
4/6/2025	2:00:00 PM	0.08
4/6/2025	2:15:00 PM	0.08
4/6/2025	2:30:00 PM	0.08
4/6/2025	2:45:00 PM	0.08
4/6/2025	3:00:00 PM	0.08
4/6/2025	3:15:00 PM	0.09
4/6/2025	3:30:00 PM	0.09
4/6/2025	3:45:00 PM	0.09
4/6/2025	4:00:00 PM	0.09
4/6/2025	4:15:00 PM	0.09
4/6/2025	4:30:00 PM	0.09
4/6/2025	4:45:00 PM	0.09
4/6/2025	5:00:00 PM	0.09
4/6/2025	5:15:00 PM	0.09
4/6/2025	5:30:00 PM	0.09
4/6/2025	5:45:00 PM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
4/6/2025	6:00:00 PM	0.09
4/6/2025	6:15:00 PM	0.09
4/6/2025	6:30:00 PM	0.09
4/6/2025	6:45:00 PM	0.09
4/6/2025	7:00:00 PM	0.09
4/6/2025	7:15:00 PM	0.09
4/6/2025	7:30:00 PM	0.09
4/6/2025	7:45:00 PM	0.09
4/6/2025	8:00:00 PM	0.09
4/6/2025	8:15:00 PM	0.09
4/6/2025	8:30:00 PM	0.09
4/6/2025	8:45:00 PM	0.09
4/6/2025	9:00:00 PM	0.09
4/6/2025	9:15:00 PM	0.09
4/6/2025	9:30:00 PM	0.09
4/6/2025	9:45:00 PM	0.09
4/6/2025	10:00:00 PM	0.09
4/6/2025	10:15:00 PM	0.09
4/6/2025	10:30:00 PM	0.09
4/6/2025	10:45:00 PM	0.09
4/6/2025	11:00:00 PM	0.09
4/6/2025	11:15:00 PM	0.09
4/6/2025	11:30:00 PM	0.09
4/6/2025	11:45:00 PM	0.09
4/7/2025	12:00:00 AM	0.09
4/7/2025	12:15:00 AM	0.09
4/7/2025	12:30:00 AM	0.09
4/7/2025	12:45:00 AM	0.09
4/7/2025	1:00:00 AM	0.09
4/7/2025	1:15:00 AM	0.09
4/7/2025	1:30:00 AM	0.09
4/7/2025	1:45:00 AM	0.09
4/7/2025	2:00:00 AM	0.09
4/7/2025	2:15:00 AM	0.09
4/7/2025	2:30:00 AM	0.09
4/7/2025	2:45:00 AM	0.09
4/7/2025	3:00:00 AM	0.1
4/7/2025	3:15:00 AM	0.1
4/7/2025	3:30:00 AM	0.1
4/7/2025	3:45:00 AM	0.1
4/7/2025	4:00:00 AM	0.1
4/7/2025	4:15:00 AM	0.1
4/7/2025	4:30:00 AM	0.1
4/7/2025	4:45:00 AM	0.1
4/7/2025	5:00:00 AM	0.1
4/7/2025	5:15:00 AM	0.1

Georges Ditch Return Gage

DATE	TIME	GAGE
4/7/2025	5:30:00 AM	0.1
4/7/2025	5:45:00 AM	0.1
4/7/2025	6:00:00 AM	0.1
4/7/2025	6:15:00 AM	0.09
4/7/2025	6:30:00 AM	0.09
4/7/2025	6:45:00 AM	0.09
4/7/2025	7:00:00 AM	0.09
4/7/2025	7:15:00 AM	0.09
4/7/2025	7:30:00 AM	0.09
4/7/2025	7:45:00 AM	0.09
4/7/2025	8:00:00 AM	0.09
4/7/2025	8:15:00 AM	0.09
4/7/2025	8:30:00 AM	0.09
4/7/2025	8:45:00 AM	0.08
4/7/2025	9:00:00 AM	0.08
4/7/2025	9:15:00 AM	0.08
4/7/2025	9:30:00 AM	0.08
4/7/2025	9:45:00 AM	0.08
4/7/2025	10:00:00 AM	0.07
4/7/2025	10:15:00 AM	0.07
4/7/2025	10:30:00 AM	0.07
4/7/2025	10:45:00 AM	0.07
4/7/2025	11:00:00 AM	0.07
4/7/2025	11:15:00 AM	0.07
4/7/2025	11:30:00 AM	0.07
4/7/2025	11:45:00 AM	0.07
4/7/2025	12:00:00 PM	0.07
4/7/2025	12:15:00 PM	0.07
4/7/2025	12:30:00 PM	0.07
4/7/2025	12:45:00 PM	0.06
4/7/2025	1:00:00 PM	0.07
4/7/2025	1:15:00 PM	0.07
4/7/2025	1:30:00 PM	0.07
4/7/2025	1:45:00 PM	0.07
4/7/2025	2:00:00 PM	0.07
4/7/2025	2:15:00 PM	0.08
4/7/2025	2:30:00 PM	0.08
4/7/2025	2:45:00 PM	0.09
4/7/2025	3:00:00 PM	0.1
4/7/2025	3:15:00 PM	0.1
4/7/2025	3:30:00 PM	0.1
4/7/2025	3:45:00 PM	0.11
4/7/2025	4:00:00 PM	0.11
4/7/2025	4:15:00 PM	0.11
4/7/2025	4:30:00 PM	0.11
4/7/2025	4:45:00 PM	0.11

Georges Ditch Return Gage

DATE	TIME	GAGE
4/7/2025	5:00:00 PM	0.11
4/7/2025	5:15:00 PM	0.11
4/7/2025	5:30:00 PM	0.11
4/7/2025	5:45:00 PM	0.11
4/7/2025	6:00:00 PM	0.11
4/7/2025	6:15:00 PM	0.11
4/7/2025	6:30:00 PM	0.12
4/7/2025	6:45:00 PM	0.11
4/7/2025	7:00:00 PM	0.11
4/7/2025	7:15:00 PM	0.11
4/7/2025	7:30:00 PM	0.11
4/7/2025	7:45:00 PM	0.11
4/7/2025	8:00:00 PM	0.11
4/7/2025	8:15:00 PM	0.11
4/7/2025	8:30:00 PM	0.12
4/7/2025	8:45:00 PM	0.12
4/7/2025	9:00:00 PM	0.11
4/7/2025	9:15:00 PM	0.12
4/7/2025	9:30:00 PM	0.11
4/7/2025	9:45:00 PM	0.11
4/7/2025	10:00:00 PM	0.11
4/7/2025	10:15:00 PM	0.11
4/7/2025	10:30:00 PM	0.11
4/7/2025	10:45:00 PM	0.11
4/7/2025	11:00:00 PM	0.11
4/7/2025	11:15:00 PM	0.11
4/7/2025	11:30:00 PM	0.11
4/7/2025	11:45:00 PM	0.11
4/8/2025	12:00:00 AM	0.11
4/8/2025	12:15:00 AM	0.11
4/8/2025	12:30:00 AM	0.11
4/8/2025	12:45:00 AM	0.11
4/8/2025	1:00:00 AM	0.11
4/8/2025	1:15:00 AM	0.11
4/8/2025	1:30:00 AM	0.11
4/8/2025	1:45:00 AM	0.11
4/8/2025	2:00:00 AM	0.11
4/8/2025	2:15:00 AM	0.11
4/8/2025	2:30:00 AM	0.11
4/8/2025	2:45:00 AM	0.11
4/8/2025	3:00:00 AM	0.12
4/8/2025	3:15:00 AM	0.12
4/8/2025	3:30:00 AM	0.12
4/8/2025	3:45:00 AM	0.12
4/8/2025	4:00:00 AM	0.12
4/8/2025	4:15:00 AM	0.12

Georges Ditch Return Gage

DATE	TIME	GAGE
4/8/2025	4:30:00 AM	0.12
4/8/2025	4:45:00 AM	0.12
4/8/2025	5:00:00 AM	0.12
4/8/2025	5:15:00 AM	0.11
4/8/2025	5:30:00 AM	0.11
4/8/2025	5:45:00 AM	0.11
4/8/2025	6:00:00 AM	0.11
4/8/2025	6:15:00 AM	0.11
4/8/2025	6:30:00 AM	0.11
4/8/2025	6:45:00 AM	0.11
4/8/2025	7:00:00 AM	0.11
4/8/2025	7:15:00 AM	0.11
4/8/2025	7:30:00 AM	0.1
4/8/2025	7:45:00 AM	0.1
4/8/2025	8:00:00 AM	0.1
4/8/2025	8:15:00 AM	0.1
4/8/2025	8:30:00 AM	0.1
4/8/2025	8:45:00 AM	0.11
4/8/2025	9:00:00 AM	0.11
4/8/2025	9:15:00 AM	0.11
4/8/2025	9:30:00 AM	0.11
4/8/2025	9:45:00 AM	0.11
4/8/2025	10:00:00 AM	0.11
4/8/2025	10:15:00 AM	0.11
4/8/2025	10:30:00 AM	0.11
4/8/2025	10:45:00 AM	0.11
4/8/2025	11:00:00 AM	0.11
4/8/2025	11:15:00 AM	0.11
4/8/2025	11:30:00 AM	0.11
4/8/2025	11:45:00 AM	0.11
4/8/2025	12:00:00 PM	0.11
4/8/2025	12:15:00 PM	0.11
4/8/2025	12:30:00 PM	0.11
4/8/2025	12:45:00 PM	0.11
4/8/2025	1:00:00 PM	0.11
4/8/2025	1:15:00 PM	0.11
4/8/2025	1:30:00 PM	0.11
4/8/2025	1:45:00 PM	0.11
4/8/2025	2:00:00 PM	0.11
4/8/2025	2:15:00 PM	0.11
4/8/2025	2:30:00 PM	0.11
4/8/2025	2:45:00 PM	0.11
4/8/2025	3:00:00 PM	0.11
4/8/2025	3:15:00 PM	0.11
4/8/2025	3:30:00 PM	0.11
4/8/2025	3:45:00 PM	0.11

Georges Ditch Return Gage

DATE	TIME	GAGE
4/8/2025	4:00:00 PM	0.11
4/8/2025	4:15:00 PM	0.11
4/8/2025	4:30:00 PM	0.11
4/8/2025	4:45:00 PM	0.11
4/8/2025	5:00:00 PM	0.11
4/8/2025	5:15:00 PM	0.11
4/8/2025	5:30:00 PM	0.11
4/8/2025	5:45:00 PM	0.11
4/8/2025	6:00:00 PM	0.11
4/8/2025	6:15:00 PM	0.11
4/8/2025	6:30:00 PM	0.11
4/8/2025	6:45:00 PM	0.11
4/8/2025	7:00:00 PM	0.11
4/8/2025	7:15:00 PM	0.11
4/8/2025	7:30:00 PM	0.11
4/8/2025	7:45:00 PM	0.11
4/8/2025	8:00:00 PM	0.11
4/8/2025	8:15:00 PM	0.11
4/8/2025	8:30:00 PM	0.11
4/8/2025	8:45:00 PM	0.11
4/8/2025	9:00:00 PM	0.11
4/8/2025	9:15:00 PM	0.11
4/8/2025	9:30:00 PM	0.11
4/8/2025	9:45:00 PM	0.11
4/8/2025	10:00:00 PM	0.11
4/8/2025	10:15:00 PM	0.11
4/8/2025	10:30:00 PM	0.11
4/8/2025	10:45:00 PM	0.11
4/8/2025	11:00:00 PM	0.11
4/8/2025	11:15:00 PM	0.11
4/8/2025	11:30:00 PM	0.11
4/8/2025	11:45:00 PM	0.11
4/9/2025	12:00:00 AM	0.11
4/9/2025	12:15:00 AM	0.11
4/9/2025	12:30:00 AM	0.11
4/9/2025	12:45:00 AM	0.11
4/9/2025	1:00:00 AM	0.11
4/9/2025	1:15:00 AM	0.11
4/9/2025	1:30:00 AM	0.11
4/9/2025	1:45:00 AM	0.11
4/9/2025	2:00:00 AM	0.11
4/9/2025	2:15:00 AM	0.11
4/9/2025	2:30:00 AM	0.11
4/9/2025	2:45:00 AM	0.11
4/9/2025	3:00:00 AM	0.11
4/9/2025	3:15:00 AM	0.11

Georges Ditch Return Gage

DATE	TIME	GAGE
4/9/2025	3:30:00 AM	0.11
4/9/2025	3:45:00 AM	0.11
4/9/2025	4:00:00 AM	0.11
4/9/2025	4:15:00 AM	0.11
4/9/2025	4:30:00 AM	0.11
4/9/2025	4:45:00 AM	0.1
4/9/2025	5:00:00 AM	0.1
4/9/2025	5:15:00 AM	0.1
4/9/2025	5:30:00 AM	0.1
4/9/2025	5:45:00 AM	0.1
4/9/2025	6:00:00 AM	0.1
4/9/2025	6:15:00 AM	0.1
4/9/2025	6:30:00 AM	0.1
4/9/2025	6:45:00 AM	0.09
4/9/2025	7:00:00 AM	0.09
4/9/2025	7:15:00 AM	0.09
4/9/2025	7:30:00 AM	0.09
4/9/2025	7:45:00 AM	0.09
4/9/2025	8:00:00 AM	0.09
4/9/2025	8:15:00 AM	0.09
4/9/2025	8:30:00 AM	0.09
4/9/2025	8:45:00 AM	0.09
4/9/2025	9:00:00 AM	0.09
4/9/2025	9:15:00 AM	0.09
4/9/2025	9:30:00 AM	0.08
4/9/2025	9:45:00 AM	0.08
4/9/2025	10:00:00 AM	0.08
4/9/2025	10:15:00 AM	0.08
4/9/2025	10:30:00 AM	0.08
4/9/2025	10:45:00 AM	0.08
4/9/2025	11:00:00 AM	0.08
4/9/2025	11:15:00 AM	0.08
4/9/2025	11:30:00 AM	0.09
4/9/2025	11:45:00 AM	0.09
4/9/2025	12:00:00 PM	0.09
4/9/2025	12:15:00 PM	0.09
4/9/2025	12:30:00 PM	0.09
4/9/2025	12:45:00 PM	0.09
4/9/2025	1:00:00 PM	0.09
4/9/2025	1:15:00 PM	0.09
4/9/2025	1:30:00 PM	0.09
4/9/2025	1:45:00 PM	0.09
4/9/2025	2:00:00 PM	0.09
4/9/2025	2:15:00 PM	0.09
4/9/2025	2:30:00 PM	0.09
4/9/2025	2:45:00 PM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
4/9/2025	3:00:00 PM	0.09
4/9/2025	3:15:00 PM	0.09
4/9/2025	3:30:00 PM	0.09
4/9/2025	3:45:00 PM	0.09
4/9/2025	4:00:00 PM	0.09
4/9/2025	4:15:00 PM	0.09
4/9/2025	4:30:00 PM	0.09
4/9/2025	4:45:00 PM	0.09
4/9/2025	5:00:00 PM	0.09
4/9/2025	5:15:00 PM	0.09
4/9/2025	5:30:00 PM	0.09
4/9/2025	5:45:00 PM	0.09
4/9/2025	6:00:00 PM	0.09
4/9/2025	6:15:00 PM	0.09
4/9/2025	6:30:00 PM	0.09
4/9/2025	6:45:00 PM	0.09
4/9/2025	7:00:00 PM	0.09
4/9/2025	7:15:00 PM	0.09
4/9/2025	7:30:00 PM	0.09
4/9/2025	7:45:00 PM	0.09
4/9/2025	8:00:00 PM	0.09
4/9/2025	8:15:00 PM	0.09
4/9/2025	8:30:00 PM	0.09
4/9/2025	8:45:00 PM	0.09
4/9/2025	9:00:00 PM	0.09
4/9/2025	9:15:00 PM	0.09
4/9/2025	9:30:00 PM	0.09
4/9/2025	9:45:00 PM	0.09
4/9/2025	10:00:00 PM	0.09
4/9/2025	10:15:00 PM	0.09
4/9/2025	10:30:00 PM	0.09
4/9/2025	10:45:00 PM	0.09
4/9/2025	11:00:00 PM	0.09
4/9/2025	11:15:00 PM	0.09
4/9/2025	11:30:00 PM	0.09
4/9/2025	11:45:00 PM	0.09
4/10/2025	12:00:00 AM	0.09
4/10/2025	12:15:00 AM	0.09
4/10/2025	12:30:00 AM	0.09
4/10/2025	12:45:00 AM	0.09
4/10/2025	1:00:00 AM	0.09
4/10/2025	1:15:00 AM	0.09
4/10/2025	1:30:00 AM	0.09
4/10/2025	1:45:00 AM	0.09
4/10/2025	2:00:00 AM	0.09
4/10/2025	2:15:00 AM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
4/10/2025	2:30:00 AM	0.09
4/10/2025	2:45:00 AM	0.09
4/10/2025	3:00:00 AM	0.09
4/10/2025	3:15:00 AM	0.09
4/10/2025	3:30:00 AM	0.09
4/10/2025	3:45:00 AM	0.08
4/10/2025	4:00:00 AM	0.08
4/10/2025	4:15:00 AM	0.08
4/10/2025	4:30:00 AM	0.08
4/10/2025	4:45:00 AM	0.08
4/10/2025	5:00:00 AM	0.07
4/10/2025	5:15:00 AM	0.07
4/10/2025	5:30:00 AM	0.07
4/10/2025	5:45:00 AM	0.07
4/10/2025	6:00:00 AM	0.07
4/10/2025	6:15:00 AM	0.06
4/10/2025	6:30:00 AM	0.06
4/10/2025	6:45:00 AM	0.06
4/10/2025	7:00:00 AM	0.07
4/10/2025	7:15:00 AM	0.07
4/10/2025	7:30:00 AM	0.08
4/10/2025	7:45:00 AM	0.08
4/10/2025	8:00:00 AM	0.07
4/10/2025	8:15:00 AM	0.07
4/10/2025	8:30:00 AM	0.07
4/10/2025	8:45:00 AM	0.07
4/10/2025	9:00:00 AM	0.08
4/10/2025	9:15:00 AM	0.08
4/10/2025	9:30:00 AM	0.08
4/10/2025	9:45:00 AM	0.08
4/10/2025	10:00:00 AM	0.08
4/10/2025	10:15:00 AM	0.08
4/10/2025	10:30:00 AM	0.07
4/10/2025	10:45:00 AM	0.07
4/10/2025	11:00:00 AM	0.07
4/10/2025	11:15:00 AM	0.07
4/10/2025	11:30:00 AM	0.07
4/10/2025	11:45:00 AM	0.07
4/10/2025	12:00:00 PM	0.07
4/10/2025	12:15:00 PM	0.08
4/10/2025	12:30:00 PM	0.08
4/10/2025	12:45:00 PM	0.08
4/10/2025	1:00:00 PM	0.08
4/10/2025	1:15:00 PM	0.08
4/10/2025	1:30:00 PM	0.07
4/10/2025	1:45:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
4/10/2025	2:00:00 PM	0.07
4/10/2025	2:15:00 PM	0.07
4/10/2025	2:30:00 PM	0.07
4/10/2025	2:45:00 PM	0.07
4/10/2025	3:00:00 PM	0.07
4/10/2025	3:15:00 PM	0.07
4/10/2025	3:30:00 PM	0.07
4/10/2025	3:45:00 PM	0.07
4/10/2025	4:00:00 PM	0.07
4/10/2025	4:15:00 PM	0.07
4/10/2025	4:30:00 PM	0.07
4/10/2025	4:45:00 PM	0.07
4/10/2025	5:00:00 PM	0.07
4/10/2025	5:15:00 PM	0.07
4/10/2025	5:30:00 PM	0.08
4/10/2025	5:45:00 PM	0.08
4/10/2025	6:00:00 PM	0.08
4/10/2025	6:15:00 PM	0.08
4/10/2025	6:30:00 PM	0.08
4/10/2025	6:45:00 PM	0.08
4/10/2025	7:00:00 PM	0.08
4/10/2025	7:15:00 PM	0.08
4/10/2025	7:30:00 PM	0.08
4/10/2025	7:45:00 PM	0.08
4/10/2025	8:00:00 PM	0.08
4/10/2025	8:15:00 PM	0.08
4/10/2025	8:30:00 PM	0.08
4/10/2025	8:45:00 PM	0.08
4/10/2025	9:00:00 PM	0.08
4/10/2025	9:15:00 PM	0.08
4/10/2025	9:30:00 PM	0.08
4/10/2025	9:45:00 PM	0.08
4/10/2025	10:00:00 PM	0.08
4/10/2025	10:15:00 PM	0.08
4/10/2025	10:30:00 PM	0.08
4/10/2025	10:45:00 PM	0.08
4/10/2025	11:00:00 PM	0.08
4/10/2025	11:15:00 PM	0.08
4/10/2025	11:30:00 PM	0.08
4/10/2025	11:45:00 PM	0.08
4/11/2025	12:00:00 AM	0.08
4/11/2025	12:15:00 AM	0.08
4/11/2025	12:30:00 AM	0.08
4/11/2025	12:45:00 AM	0.08
4/11/2025	1:00:00 AM	0.08
4/11/2025	1:15:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
4/11/2025	1:30:00 AM	0.08
4/11/2025	1:45:00 AM	0.08
4/11/2025	2:00:00 AM	0.07
4/11/2025	2:15:00 AM	0.07
4/11/2025	2:30:00 AM	0.07
4/11/2025	2:45:00 AM	0.07
4/11/2025	3:00:00 AM	0.07
4/11/2025	3:15:00 AM	0.07
4/11/2025	3:30:00 AM	0.07
4/11/2025	3:45:00 AM	0.08
4/11/2025	4:00:00 AM	0.08
4/11/2025	4:15:00 AM	0.08
4/11/2025	4:30:00 AM	0.08
4/11/2025	4:45:00 AM	0.07
4/11/2025	5:00:00 AM	0.08
4/11/2025	5:15:00 AM	0.08
4/11/2025	5:30:00 AM	0.08
4/11/2025	5:45:00 AM	0.08
4/11/2025	6:00:00 AM	0.07
4/11/2025	6:15:00 AM	0.08
4/11/2025	6:30:00 AM	0.07
4/11/2025	6:45:00 AM	0.07
4/11/2025	7:00:00 AM	0.07
4/11/2025	7:15:00 AM	0.07
4/11/2025	7:30:00 AM	0.07
4/11/2025	7:45:00 AM	0.07
4/11/2025	8:00:00 AM	0.07
4/11/2025	8:15:00 AM	0.07
4/11/2025	8:30:00 AM	0.07
4/11/2025	8:45:00 AM	0.07
4/11/2025	9:00:00 AM	0.07
4/11/2025	9:15:00 AM	0.07
4/11/2025	9:30:00 AM	0.07
4/11/2025	9:45:00 AM	0.07
4/11/2025	10:00:00 AM	0.07
4/11/2025	10:15:00 AM	0.07
4/11/2025	10:30:00 AM	0.07
4/11/2025	10:45:00 AM	0.07
4/11/2025	11:00:00 AM	0.07
4/11/2025	11:15:00 AM	0.07
4/11/2025	11:30:00 AM	0.06
4/11/2025	11:45:00 AM	0.06
4/11/2025	12:00:00 PM	0.06
4/11/2025	12:15:00 PM	0.06
4/11/2025	12:30:00 PM	0.06
4/11/2025	12:45:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
4/11/2025	1:00:00 PM	0.06
4/11/2025	1:15:00 PM	0.06
4/11/2025	1:30:00 PM	0.06
4/11/2025	1:45:00 PM	0.05
4/11/2025	2:00:00 PM	0.05
4/11/2025	2:15:00 PM	0.05
4/11/2025	2:30:00 PM	0.06
4/11/2025	2:45:00 PM	0.06
4/11/2025	3:00:00 PM	0.06
4/11/2025	3:15:00 PM	0.06
4/11/2025	3:30:00 PM	0.07
4/11/2025	3:45:00 PM	0.07
4/11/2025	4:00:00 PM	0.07
4/11/2025	4:15:00 PM	0.07
4/11/2025	4:30:00 PM	0.07
4/11/2025	4:45:00 PM	0.07
4/11/2025	5:00:00 PM	0.07
4/11/2025	5:15:00 PM	0.07
4/11/2025	5:30:00 PM	0.07
4/11/2025	5:45:00 PM	0.07
4/11/2025	6:00:00 PM	0.07
4/11/2025	6:15:00 PM	0.07
4/11/2025	6:30:00 PM	0.07
4/11/2025	6:45:00 PM	0.07
4/11/2025	7:00:00 PM	0.07
4/11/2025	7:15:00 PM	0.07
4/11/2025	7:30:00 PM	0.07
4/11/2025	7:45:00 PM	0.07
4/11/2025	8:00:00 PM	0.07
4/11/2025	8:15:00 PM	0.07
4/11/2025	8:30:00 PM	0.07
4/11/2025	8:45:00 PM	0.07
4/11/2025	9:00:00 PM	0.07
4/11/2025	9:15:00 PM	0.07
4/11/2025	9:30:00 PM	0.07
4/11/2025	9:45:00 PM	0.07
4/11/2025	10:00:00 PM	0.07
4/11/2025	10:15:00 PM	0.07
4/11/2025	10:30:00 PM	0.07
4/11/2025	10:45:00 PM	0.07
4/11/2025	11:00:00 PM	0.07
4/11/2025	11:15:00 PM	0.07
4/11/2025	11:30:00 PM	0.07
4/11/2025	11:45:00 PM	0.07
4/12/2025	12:00:00 AM	0.07
4/12/2025	12:15:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
4/12/2025	12:30:00 AM	0.07
4/12/2025	12:45:00 AM	0.07
4/12/2025	1:00:00 AM	0.07
4/12/2025	1:15:00 AM	0.07
4/12/2025	1:30:00 AM	0.07
4/12/2025	1:45:00 AM	0.07
4/12/2025	2:00:00 AM	0.07
4/12/2025	2:15:00 AM	0.07
4/12/2025	2:30:00 AM	0.07
4/12/2025	2:45:00 AM	0.07
4/12/2025	3:00:00 AM	0.07
4/12/2025	3:15:00 AM	0.07
4/12/2025	3:30:00 AM	0.07
4/12/2025	3:45:00 AM	0.07
4/12/2025	4:00:00 AM	0.07
4/12/2025	4:15:00 AM	0.07
4/12/2025	4:30:00 AM	0.07
4/12/2025	4:45:00 AM	0.07
4/12/2025	5:00:00 AM	0.07
4/12/2025	5:15:00 AM	0.07
4/12/2025	5:30:00 AM	0.07
4/12/2025	5:45:00 AM	0.07
4/12/2025	6:00:00 AM	0.07
4/12/2025	6:15:00 AM	0.07
4/12/2025	6:30:00 AM	0.07
4/12/2025	6:45:00 AM	0.07
4/12/2025	7:00:00 AM	0.07
4/12/2025	7:15:00 AM	0.07
4/12/2025	7:30:00 AM	0.07
4/12/2025	7:45:00 AM	0.07
4/12/2025	8:00:00 AM	0.07
4/12/2025	8:15:00 AM	0.06
4/12/2025	8:30:00 AM	0.06
4/12/2025	8:45:00 AM	0.06
4/12/2025	9:00:00 AM	0.06
4/12/2025	9:15:00 AM	0.06
4/12/2025	9:30:00 AM	0.06
4/12/2025	9:45:00 AM	0.06
4/12/2025	10:00:00 AM	0.06
4/12/2025	10:15:00 AM	0.06
4/12/2025	10:30:00 AM	0.06
4/12/2025	10:45:00 AM	0.06
4/12/2025	11:00:00 AM	0.06
4/12/2025	11:15:00 AM	0.06
4/12/2025	11:30:00 AM	0.06
4/12/2025	11:45:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
4/12/2025	12:00:00 PM	0.06
4/12/2025	12:15:00 PM	0.06
4/12/2025	12:30:00 PM	0.06
4/12/2025	12:45:00 PM	0.06
4/12/2025	1:00:00 PM	0.06
4/12/2025	1:15:00 PM	0.07
4/12/2025	1:30:00 PM	0.07
4/12/2025	1:45:00 PM	0.07
4/12/2025	2:00:00 PM	0.07
4/12/2025	2:15:00 PM	0.07
4/12/2025	2:30:00 PM	0.07
4/12/2025	2:45:00 PM	0.07
4/12/2025	3:00:00 PM	0.07
4/12/2025	3:15:00 PM	0.07
4/12/2025	3:30:00 PM	0.07
4/12/2025	3:45:00 PM	0.07
4/12/2025	4:00:00 PM	0.07
4/12/2025	4:15:00 PM	0.07
4/12/2025	4:30:00 PM	0.07
4/12/2025	4:45:00 PM	0.07
4/12/2025	5:00:00 PM	0.07
4/12/2025	5:15:00 PM	0.07
4/12/2025	5:30:00 PM	0.07
4/12/2025	5:45:00 PM	0.07
4/12/2025	6:00:00 PM	0.07
4/12/2025	6:15:00 PM	0.07
4/12/2025	6:30:00 PM	0.07
4/12/2025	6:45:00 PM	0.07
4/12/2025	7:00:00 PM	0.07
4/12/2025	7:15:00 PM	0.07
4/12/2025	7:30:00 PM	0.07
4/12/2025	7:45:00 PM	0.07
4/12/2025	8:00:00 PM	0.07
4/12/2025	8:15:00 PM	0.07
4/12/2025	8:30:00 PM	0.07
4/12/2025	8:45:00 PM	0.07
4/12/2025	9:00:00 PM	0.07
4/12/2025	9:15:00 PM	0.07
4/12/2025	9:30:00 PM	0.07
4/12/2025	9:45:00 PM	0.07
4/12/2025	10:00:00 PM	0.07
4/12/2025	10:15:00 PM	0.07
4/12/2025	10:30:00 PM	0.07
4/12/2025	10:45:00 PM	0.07
4/12/2025	11:00:00 PM	0.07
4/12/2025	11:15:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
4/12/2025	11:30:00 PM	0.07
4/12/2025	11:45:00 PM	0.07
4/13/2025	12:00:00 AM	0.07
4/13/2025	12:15:00 AM	0.07
4/13/2025	12:30:00 AM	0.07
4/13/2025	12:45:00 AM	0.07
4/13/2025	1:00:00 AM	0.07
4/13/2025	1:15:00 AM	0.07
4/13/2025	1:30:00 AM	0.07
4/13/2025	1:45:00 AM	0.07
4/13/2025	2:00:00 AM	0.07
4/13/2025	2:15:00 AM	0.07
4/13/2025	2:30:00 AM	0.07
4/13/2025	2:45:00 AM	0.07
4/13/2025	3:00:00 AM	0.07
4/13/2025	3:15:00 AM	0.06
4/13/2025	3:30:00 AM	0.06
4/13/2025	3:45:00 AM	0.06
4/13/2025	4:00:00 AM	0.06
4/13/2025	4:15:00 AM	0.06
4/13/2025	4:30:00 AM	0.06
4/13/2025	4:45:00 AM	0.06
4/13/2025	5:00:00 AM	0.06
4/13/2025	5:15:00 AM	0.06
4/13/2025	5:30:00 AM	0.06
4/13/2025	5:45:00 AM	0.06
4/13/2025	6:00:00 AM	0.06
4/13/2025	6:15:00 AM	0.06
4/13/2025	6:30:00 AM	0.06
4/13/2025	6:45:00 AM	0.06
4/13/2025	7:00:00 AM	0.06
4/13/2025	7:15:00 AM	0.06
4/13/2025	7:30:00 AM	0.07
4/13/2025	7:45:00 AM	0.06
4/13/2025	8:00:00 AM	0.06
4/13/2025	8:15:00 AM	0.06
4/13/2025	8:30:00 AM	0.06
4/13/2025	8:45:00 AM	0.06
4/13/2025	9:00:00 AM	0.06
4/13/2025	9:15:00 AM	0.06
4/13/2025	9:30:00 AM	0.05
4/13/2025	9:45:00 AM	0.05
4/13/2025	10:00:00 AM	0.05
4/13/2025	10:15:00 AM	0.06
4/13/2025	10:30:00 AM	0.06
4/13/2025	10:45:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
4/13/2025	11:00:00 AM	0.06
4/13/2025	11:15:00 AM	0.06
4/13/2025	11:30:00 AM	0.06
4/13/2025	11:45:00 AM	0.06
4/13/2025	12:00:00 PM	0.06
4/13/2025	12:15:00 PM	0.06
4/13/2025	12:30:00 PM	0.06
4/13/2025	12:45:00 PM	0.06
4/13/2025	1:00:00 PM	0.06
4/13/2025	1:15:00 PM	0.06
4/13/2025	1:30:00 PM	0.06
4/13/2025	1:45:00 PM	0.06
4/13/2025	2:00:00 PM	0.06
4/13/2025	2:15:00 PM	0.06
4/13/2025	2:30:00 PM	0.06
4/13/2025	2:45:00 PM	0.06
4/13/2025	3:00:00 PM	0.06
4/13/2025	3:15:00 PM	0.06
4/13/2025	3:30:00 PM	0.06
4/13/2025	3:45:00 PM	0.06
4/13/2025	4:00:00 PM	0.06
4/13/2025	4:15:00 PM	0.06
4/13/2025	4:30:00 PM	0.06
4/13/2025	4:45:00 PM	0.06
4/13/2025	5:00:00 PM	0.06
4/13/2025	5:15:00 PM	0.06
4/13/2025	5:30:00 PM	0.06
4/13/2025	5:45:00 PM	0.06
4/13/2025	6:00:00 PM	0.06
4/13/2025	6:15:00 PM	0.06
4/13/2025	6:30:00 PM	0.06
4/13/2025	6:45:00 PM	0.06
4/13/2025	7:00:00 PM	0.06
4/13/2025	7:15:00 PM	0.06
4/13/2025	7:30:00 PM	0.07
4/13/2025	7:45:00 PM	0.07
4/13/2025	8:00:00 PM	0.07
4/13/2025	8:15:00 PM	0.07
4/13/2025	8:30:00 PM	0.07
4/13/2025	8:45:00 PM	0.07
4/13/2025	9:00:00 PM	0.07
4/13/2025	9:15:00 PM	0.07
4/13/2025	9:30:00 PM	0.07
4/13/2025	9:45:00 PM	0.07
4/13/2025	10:00:00 PM	0.07
4/13/2025	10:15:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
4/13/2025	10:30:00 PM	0.06
4/13/2025	10:45:00 PM	0.07
4/13/2025	11:00:00 PM	0.06
4/13/2025	11:15:00 PM	0.06
4/13/2025	11:30:00 PM	0.06
4/13/2025	11:45:00 PM	0.06
4/14/2025	12:00:00 AM	0.06
4/14/2025	12:15:00 AM	0.06
4/14/2025	12:30:00 AM	0.06
4/14/2025	12:45:00 AM	0.06
4/14/2025	1:00:00 AM	0.06
4/14/2025	1:15:00 AM	0.06
4/14/2025	1:30:00 AM	0.06
4/14/2025	1:45:00 AM	0.06
4/14/2025	2:00:00 AM	0.06
4/14/2025	2:15:00 AM	0.06
4/14/2025	2:30:00 AM	0.06
4/14/2025	2:45:00 AM	0.06
4/14/2025	3:00:00 AM	0.06
4/14/2025	3:15:00 AM	0.06
4/14/2025	3:30:00 AM	0.06
4/14/2025	3:45:00 AM	0.06
4/14/2025	4:00:00 AM	0.06
4/14/2025	4:15:00 AM	0.06
4/14/2025	4:30:00 AM	0.06
4/14/2025	4:45:00 AM	0.06
4/14/2025	5:00:00 AM	0.06
4/14/2025	5:15:00 AM	0.06
4/14/2025	5:30:00 AM	0.06
4/14/2025	5:45:00 AM	0.06
4/14/2025	6:00:00 AM	0.06
4/14/2025	6:15:00 AM	0.06
4/14/2025	6:30:00 AM	0.06
4/14/2025	6:45:00 AM	0.06
4/14/2025	7:00:00 AM	0.06
4/14/2025	7:15:00 AM	0.06
4/14/2025	7:30:00 AM	0.06
4/14/2025	7:45:00 AM	0.06
4/14/2025	8:00:00 AM	0.06
4/14/2025	8:15:00 AM	0.06
4/14/2025	8:30:00 AM	0.06
4/14/2025	8:45:00 AM	0.06
4/14/2025	9:00:00 AM	0.06
4/14/2025	9:15:00 AM	0.06
4/14/2025	9:30:00 AM	0.05
4/14/2025	9:45:00 AM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
4/14/2025	10:00:00 AM	0.05
4/14/2025	10:15:00 AM	0.05
4/14/2025	10:30:00 AM	0.05
4/14/2025	10:45:00 AM	0.05
4/14/2025	11:00:00 AM	0.05
4/14/2025	11:15:00 AM	0.05
4/14/2025	11:30:00 AM	0.05
4/14/2025	11:45:00 AM	0.05
4/14/2025	12:00:00 PM	0.05
4/14/2025	12:15:00 PM	0.05
4/14/2025	12:30:00 PM	0.05
4/14/2025	12:45:00 PM	0.05
4/14/2025	1:00:00 PM	0.05
4/14/2025	1:15:00 PM	0.05
4/14/2025	1:30:00 PM	0.05
4/14/2025	1:45:00 PM	0.05
4/14/2025	2:00:00 PM	0.05
4/14/2025	2:15:00 PM	0.05
4/14/2025	2:30:00 PM	0.05
4/14/2025	2:45:00 PM	0.05
4/14/2025	3:00:00 PM	0.05
4/14/2025	3:15:00 PM	0.05
4/14/2025	3:30:00 PM	0.05
4/14/2025	3:45:00 PM	0.05
4/14/2025	4:00:00 PM	0.06
4/14/2025	4:15:00 PM	0.06
4/14/2025	4:30:00 PM	0.07
4/14/2025	4:45:00 PM	0.07
4/14/2025	5:00:00 PM	0.07
4/14/2025	5:15:00 PM	0.07
4/14/2025	5:30:00 PM	0.07
4/14/2025	5:45:00 PM	0.07
4/14/2025	6:00:00 PM	0.07
4/14/2025	6:15:00 PM	0.07
4/14/2025	6:30:00 PM	0.07
4/14/2025	6:45:00 PM	0.07
4/14/2025	7:00:00 PM	0.07
4/14/2025	7:15:00 PM	0.07
4/14/2025	7:30:00 PM	0.07
4/14/2025	7:45:00 PM	0.07
4/14/2025	8:00:00 PM	0.07
4/14/2025	8:15:00 PM	0.07
4/14/2025	8:30:00 PM	0.07
4/14/2025	8:45:00 PM	0.07
4/14/2025	9:00:00 PM	0.07
4/14/2025	9:15:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
4/14/2025	9:30:00 PM	0.07
4/14/2025	9:45:00 PM	0.07
4/14/2025	10:00:00 PM	0.07
4/14/2025	10:15:00 PM	0.07
4/14/2025	10:30:00 PM	0.07
4/14/2025	10:45:00 PM	0.07
4/14/2025	11:00:00 PM	0.07
4/14/2025	11:15:00 PM	0.07
4/14/2025	11:30:00 PM	0.07
4/14/2025	11:45:00 PM	0.07
4/15/2025	12:00:00 AM	0.07
4/15/2025	12:15:00 AM	0.07
4/15/2025	12:30:00 AM	0.07
4/15/2025	12:45:00 AM	0.07
4/15/2025	1:00:00 AM	0.07
4/15/2025	1:15:00 AM	0.07
4/15/2025	1:30:00 AM	0.07
4/15/2025	1:45:00 AM	0.07
4/15/2025	2:00:00 AM	0.07
4/15/2025	2:15:00 AM	0.07
4/15/2025	2:30:00 AM	0.07
4/15/2025	2:45:00 AM	0.06
4/15/2025	3:00:00 AM	0.06
4/15/2025	3:15:00 AM	0.06
4/15/2025	3:30:00 AM	0.06
4/15/2025	3:45:00 AM	0.06
4/15/2025	4:00:00 AM	0.05
4/15/2025	4:15:00 AM	0.05
4/15/2025	4:30:00 AM	0.05
4/15/2025	4:45:00 AM	0.05
4/15/2025	5:00:00 AM	0.05
4/15/2025	5:15:00 AM	0.05
4/15/2025	5:30:00 AM	0.05
4/15/2025	5:45:00 AM	0.05
4/15/2025	6:00:00 AM	0.04
4/15/2025	6:15:00 AM	0.04
4/15/2025	6:30:00 AM	0.04
4/15/2025	6:45:00 AM	0.04
4/15/2025	7:00:00 AM	0.04
4/15/2025	7:15:00 AM	0.04
4/15/2025	7:30:00 AM	0.04
4/15/2025	7:45:00 AM	0.04
4/15/2025	8:00:00 AM	0.04
4/15/2025	8:15:00 AM	0.04
4/15/2025	8:30:00 AM	0.04
4/15/2025	8:45:00 AM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
4/15/2025	9:00:00 AM	0.04
4/15/2025	9:15:00 AM	0.04
4/15/2025	9:30:00 AM	0.04
4/15/2025	9:45:00 AM	0.04
4/15/2025	10:00:00 AM	0.03
4/15/2025	10:15:00 AM	0.04
4/15/2025	10:30:00 AM	0.04
4/15/2025	10:45:00 AM	0.04
4/15/2025	11:00:00 AM	0.05
4/15/2025	11:15:00 AM	0.05
4/15/2025	11:30:00 AM	0.05
4/15/2025	11:45:00 AM	0.05
4/15/2025	12:00:00 PM	0.05
4/15/2025	12:15:00 PM	0.05
4/15/2025	12:30:00 PM	0.06
4/15/2025	12:45:00 PM	0.06
4/15/2025	1:00:00 PM	0.06
4/15/2025	1:15:00 PM	0.06
4/15/2025	1:30:00 PM	0.06
4/15/2025	1:45:00 PM	0.06
4/15/2025	2:00:00 PM	0.05
4/15/2025	2:15:00 PM	0.06
4/15/2025	2:30:00 PM	0.06
4/15/2025	2:45:00 PM	0.06
4/15/2025	3:00:00 PM	0.06
4/15/2025	3:15:00 PM	0.06
4/15/2025	3:30:00 PM	0.06
4/15/2025	3:45:00 PM	0.06
4/15/2025	4:00:00 PM	0.06
4/15/2025	4:15:00 PM	0.06
4/15/2025	4:30:00 PM	0.06
4/15/2025	4:45:00 PM	0.06
4/15/2025	5:00:00 PM	0.06
4/15/2025	5:15:00 PM	0.06
4/15/2025	5:30:00 PM	0.06
4/15/2025	5:45:00 PM	0.06
4/15/2025	6:00:00 PM	0.06
4/15/2025	6:15:00 PM	0.06
4/15/2025	6:30:00 PM	0.06
4/15/2025	6:45:00 PM	0.06
4/15/2025	7:00:00 PM	0.06
4/15/2025	7:15:00 PM	0.06
4/15/2025	7:30:00 PM	0.06
4/15/2025	7:45:00 PM	0.06
4/15/2025	8:00:00 PM	0.06
4/15/2025	8:15:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
4/15/2025	8:30:00 PM	0.06
4/15/2025	8:45:00 PM	0.06
4/15/2025	9:00:00 PM	0.06
4/15/2025	9:15:00 PM	0.06
4/15/2025	9:30:00 PM	0.06
4/15/2025	9:45:00 PM	0.06
4/15/2025	10:00:00 PM	0.06
4/15/2025	10:15:00 PM	0.06
4/15/2025	10:30:00 PM	0.06
4/15/2025	10:45:00 PM	0.06
4/15/2025	11:00:00 PM	0.06
4/15/2025	11:15:00 PM	0.06
4/15/2025	11:30:00 PM	0.06
4/15/2025	11:45:00 PM	0.06
4/16/2025	12:00:00 AM	0.06
4/16/2025	12:15:00 AM	0.06
4/16/2025	12:30:00 AM	0.06
4/16/2025	12:45:00 AM	0.06
4/16/2025	1:00:00 AM	0.06
4/16/2025	1:15:00 AM	0.06
4/16/2025	1:30:00 AM	0.06
4/16/2025	1:45:00 AM	0.06
4/16/2025	2:00:00 AM	0.06
4/16/2025	2:15:00 AM	0.06
4/16/2025	2:30:00 AM	0.06
4/16/2025	2:45:00 AM	0.06
4/16/2025	3:00:00 AM	0.06
4/16/2025	3:15:00 AM	0.06
4/16/2025	3:30:00 AM	0.07
4/16/2025	3:45:00 AM	0.07
4/16/2025	4:00:00 AM	0.06
4/16/2025	4:15:00 AM	0.07
4/16/2025	4:30:00 AM	0.06
4/16/2025	4:45:00 AM	0.06
4/16/2025	5:00:00 AM	0.07
4/16/2025	5:15:00 AM	0.06
4/16/2025	5:30:00 AM	0.06
4/16/2025	5:45:00 AM	0.06
4/16/2025	6:00:00 AM	0.06
4/16/2025	6:15:00 AM	0.06
4/16/2025	6:30:00 AM	0.06
4/16/2025	6:45:00 AM	0.06
4/16/2025	7:00:00 AM	0.06
4/16/2025	7:15:00 AM	0.06
4/16/2025	7:30:00 AM	0.06
4/16/2025	7:45:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
4/16/2025	8:00:00 AM	0.06
4/16/2025	8:15:00 AM	0.06
4/16/2025	8:30:00 AM	0.06
4/16/2025	8:45:00 AM	0.06
4/16/2025	9:00:00 AM	0.06
4/16/2025	9:15:00 AM	0.06
4/16/2025	9:30:00 AM	0.06
4/16/2025	9:45:00 AM	0.06
4/16/2025	10:00:00 AM	0.06
4/16/2025	10:15:00 AM	0.06
4/16/2025	10:30:00 AM	0.06
4/16/2025	10:45:00 AM	0.05
4/16/2025	11:00:00 AM	0.05
4/16/2025	11:15:00 AM	0.05
4/16/2025	11:30:00 AM	0.05
4/16/2025	11:45:00 AM	0.05
4/16/2025	12:00:00 PM	0.05
4/16/2025	12:15:00 PM	0.05
4/16/2025	12:30:00 PM	0.05
4/16/2025	12:45:00 PM	0.05
4/16/2025	1:00:00 PM	0.05
4/16/2025	1:15:00 PM	0.05
4/16/2025	1:30:00 PM	0.05
4/16/2025	1:45:00 PM	0.05
4/16/2025	2:00:00 PM	0.05
4/16/2025	2:15:00 PM	0.05
4/16/2025	2:30:00 PM	0.05
4/16/2025	2:45:00 PM	0.05
4/16/2025	3:00:00 PM	0.05
4/16/2025	3:15:00 PM	0.05
4/16/2025	3:30:00 PM	0.05
4/16/2025	3:45:00 PM	0.05
4/16/2025	4:00:00 PM	0.05
4/16/2025	4:15:00 PM	0.05
4/16/2025	4:30:00 PM	0.05
4/16/2025	4:45:00 PM	0.05
4/16/2025	5:00:00 PM	0.05
4/16/2025	5:15:00 PM	0.05
4/16/2025	5:30:00 PM	0.05
4/16/2025	5:45:00 PM	0.05
4/16/2025	6:00:00 PM	0.05
4/16/2025	6:15:00 PM	0.05
4/16/2025	6:30:00 PM	0.05
4/16/2025	6:45:00 PM	0.05
4/16/2025	7:00:00 PM	0.05
4/16/2025	7:15:00 PM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
4/16/2025	7:30:00 PM	0.05
4/16/2025	7:45:00 PM	0.05
4/16/2025	8:00:00 PM	0.05
4/16/2025	8:15:00 PM	0.05
4/16/2025	8:30:00 PM	0.05
4/16/2025	8:45:00 PM	0.05
4/16/2025	9:00:00 PM	0.05
4/16/2025	9:15:00 PM	0.05
4/16/2025	9:30:00 PM	0.05
4/16/2025	9:45:00 PM	0.05
4/16/2025	10:00:00 PM	0.05
4/16/2025	10:15:00 PM	0.05
4/16/2025	10:30:00 PM	0.05
4/16/2025	10:45:00 PM	0.05
4/16/2025	11:00:00 PM	0.05
4/16/2025	11:15:00 PM	0.05
4/16/2025	11:30:00 PM	0.05
4/16/2025	11:45:00 PM	0.05
4/17/2025	12:00:00 AM	0.05
4/17/2025	12:15:00 AM	0.05
4/17/2025	12:30:00 AM	0.05
4/17/2025	12:45:00 AM	0.05
4/17/2025	1:00:00 AM	0.05
4/17/2025	1:15:00 AM	0.05
4/17/2025	1:30:00 AM	0.05
4/17/2025	1:45:00 AM	0.05
4/17/2025	2:00:00 AM	0.05
4/17/2025	2:15:00 AM	0.05
4/17/2025	2:30:00 AM	0.05
4/17/2025	2:45:00 AM	0.05
4/17/2025	3:00:00 AM	0.05
4/17/2025	3:15:00 AM	0.04
4/17/2025	3:30:00 AM	0.04
4/17/2025	3:45:00 AM	0.04
4/17/2025	4:00:00 AM	0.04
4/17/2025	4:15:00 AM	0.04
4/17/2025	4:30:00 AM	0.04
4/17/2025	4:45:00 AM	0.04
4/17/2025	5:00:00 AM	0.04
4/17/2025	5:15:00 AM	0.04
4/17/2025	5:30:00 AM	0.04
4/17/2025	5:45:00 AM	0.04
4/17/2025	6:00:00 AM	0.04
4/17/2025	6:15:00 AM	0.04
4/17/2025	6:30:00 AM	0.04
4/17/2025	6:45:00 AM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
4/17/2025	7:00:00 AM	0.04
4/17/2025	7:15:00 AM	0.04
4/17/2025	7:30:00 AM	0.04
4/17/2025	7:45:00 AM	0.04
4/17/2025	8:00:00 AM	0.04
4/17/2025	8:15:00 AM	0.04
4/17/2025	8:30:00 AM	0.04
4/17/2025	8:45:00 AM	0.04
4/17/2025	9:00:00 AM	0.04
4/17/2025	9:15:00 AM	0.04
4/17/2025	9:30:00 AM	0.04
4/17/2025	9:45:00 AM	0.04
4/17/2025	10:00:00 AM	0.04
4/17/2025	10:15:00 AM	0.04
4/17/2025	10:30:00 AM	0.04
4/17/2025	10:45:00 AM	0.04
4/17/2025	11:00:00 AM	0.04
4/17/2025	11:15:00 AM	0.04
4/17/2025	11:30:00 AM	0.04
4/17/2025	11:45:00 AM	0.04
4/17/2025	12:00:00 PM	0.04
4/17/2025	12:15:00 PM	0.04
4/17/2025	12:30:00 PM	0.04
4/17/2025	12:45:00 PM	0.04
4/17/2025	1:00:00 PM	0.04
4/17/2025	1:15:00 PM	0.04
4/17/2025	1:30:00 PM	0.04
4/17/2025	1:45:00 PM	0.04
4/17/2025	2:00:00 PM	0.04
4/17/2025	2:15:00 PM	0.04
4/17/2025	2:30:00 PM	0.04
4/17/2025	2:45:00 PM	0.04
4/17/2025	3:00:00 PM	0.04
4/17/2025	3:15:00 PM	0.04
4/17/2025	3:30:00 PM	0.04
4/17/2025	3:45:00 PM	0.04
4/17/2025	4:00:00 PM	0.04
4/17/2025	4:15:00 PM	0.04
4/17/2025	4:30:00 PM	0.04
4/17/2025	4:45:00 PM	0.04
4/17/2025	5:00:00 PM	0.04
4/17/2025	5:15:00 PM	0.04
4/17/2025	5:30:00 PM	0.04
4/17/2025	5:45:00 PM	0.04
4/17/2025	6:00:00 PM	0.04
4/17/2025	6:15:00 PM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
4/17/2025	6:30:00 PM	0.04
4/17/2025	6:45:00 PM	0.04
4/17/2025	7:00:00 PM	0.04
4/17/2025	7:15:00 PM	0.04
4/17/2025	7:30:00 PM	0.04
4/17/2025	7:45:00 PM	0.04
4/17/2025	8:00:00 PM	0.04
4/17/2025	8:15:00 PM	0.04
4/17/2025	8:30:00 PM	0.04
4/17/2025	8:45:00 PM	0.04
4/17/2025	9:00:00 PM	0.04
4/17/2025	9:15:00 PM	0.04
4/17/2025	9:30:00 PM	0.04
4/17/2025	9:45:00 PM	0.04
4/17/2025	10:00:00 PM	0.04
4/17/2025	10:15:00 PM	0.04
4/17/2025	10:30:00 PM	0.04
4/17/2025	10:45:00 PM	0.04
4/17/2025	11:00:00 PM	0.04
4/17/2025	11:15:00 PM	0.04
4/17/2025	11:30:00 PM	0.04
4/17/2025	11:45:00 PM	0.04
4/18/2025	12:00:00 AM	0.04
4/18/2025	12:15:00 AM	0.04
4/18/2025	12:30:00 AM	0.04
4/18/2025	12:45:00 AM	0.04
4/18/2025	1:00:00 AM	0.04
4/18/2025	1:15:00 AM	0.04
4/18/2025	1:30:00 AM	0.04
4/18/2025	1:45:00 AM	0.04
4/18/2025	2:00:00 AM	0.04
4/18/2025	2:15:00 AM	0.04
4/18/2025	2:30:00 AM	0.04
4/18/2025	2:45:00 AM	0.04
4/18/2025	3:00:00 AM	0.04
4/18/2025	3:15:00 AM	0.04
4/18/2025	3:30:00 AM	0.04
4/18/2025	3:45:00 AM	0.04
4/18/2025	4:00:00 AM	0.04
4/18/2025	4:15:00 AM	0.04
4/18/2025	4:30:00 AM	0.04
4/18/2025	4:45:00 AM	0.04
4/18/2025	5:00:00 AM	0.04
4/18/2025	5:15:00 AM	0.04
4/18/2025	5:30:00 AM	0.04
4/18/2025	5:45:00 AM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
4/18/2025	6:00:00 AM	0.04
4/18/2025	6:15:00 AM	0.04
4/18/2025	6:30:00 AM	0.04
4/18/2025	6:45:00 AM	0.04
4/18/2025	7:00:00 AM	0.04
4/18/2025	7:15:00 AM	0.04
4/18/2025	7:30:00 AM	0.04
4/18/2025	7:45:00 AM	0.04
4/18/2025	8:00:00 AM	0.04
4/18/2025	8:15:00 AM	0.04
4/18/2025	8:30:00 AM	0.04
4/18/2025	8:45:00 AM	0.04
4/18/2025	9:00:00 AM	0.04
4/18/2025	9:15:00 AM	0.04
4/18/2025	9:30:00 AM	0.04
4/18/2025	9:45:00 AM	0.04
4/18/2025	10:00:00 AM	0.04
4/18/2025	10:15:00 AM	0.04
4/18/2025	10:30:00 AM	0.03
4/18/2025	10:45:00 AM	0.03
4/18/2025	11:00:00 AM	0.03
4/18/2025	11:15:00 AM	0.03
4/18/2025	11:30:00 AM	0.03
4/18/2025	11:45:00 AM	0.03
4/18/2025	12:00:00 PM	0.03
4/18/2025	12:15:00 PM	0.03
4/18/2025	12:30:00 PM	0.03
4/18/2025	12:45:00 PM	0.03
4/18/2025	1:00:00 PM	0.03
4/18/2025	1:15:00 PM	0.03
4/18/2025	1:30:00 PM	0.03
4/18/2025	1:45:00 PM	0.03
4/18/2025	2:00:00 PM	0.03
4/18/2025	2:15:00 PM	0.03
4/18/2025	2:30:00 PM	0.03
4/18/2025	2:45:00 PM	0.03
4/18/2025	3:00:00 PM	0.03
4/18/2025	3:15:00 PM	0.03
4/18/2025	3:30:00 PM	0.03
4/18/2025	3:45:00 PM	0.03
4/18/2025	4:00:00 PM	0.03
4/18/2025	4:15:00 PM	0.03
4/18/2025	4:30:00 PM	0.03
4/18/2025	4:45:00 PM	0.03
4/18/2025	5:00:00 PM	0.03
4/18/2025	5:15:00 PM	0.03

Georges Ditch Return Gage

DATE	TIME	GAGE
4/18/2025	5:30:00 PM	0.03
4/18/2025	5:45:00 PM	0.03
4/18/2025	6:00:00 PM	0.03
4/18/2025	6:15:00 PM	0.03
4/18/2025	6:30:00 PM	0.03
4/18/2025	6:45:00 PM	0.04
4/18/2025	7:00:00 PM	0.04
4/18/2025	7:15:00 PM	0.04
4/18/2025	7:30:00 PM	0.04
4/18/2025	7:45:00 PM	0.04
4/18/2025	8:00:00 PM	0.04
4/18/2025	8:15:00 PM	0.04
4/18/2025	8:30:00 PM	0.04
4/18/2025	8:45:00 PM	0.04
4/18/2025	9:00:00 PM	0.04
4/18/2025	9:15:00 PM	0.04
4/18/2025	9:30:00 PM	0.04
4/18/2025	9:45:00 PM	0.04
4/18/2025	10:00:00 PM	0.04
4/18/2025	10:15:00 PM	0.04
4/18/2025	10:30:00 PM	0.04
4/18/2025	10:45:00 PM	0.04
4/18/2025	11:00:00 PM	0.04
4/18/2025	11:15:00 PM	0.04
4/18/2025	11:30:00 PM	0.04
4/18/2025	11:45:00 PM	0.04
4/19/2025	12:00:00 AM	0.04
4/19/2025	12:15:00 AM	0.04
4/19/2025	12:30:00 AM	0.04
4/19/2025	12:45:00 AM	0.04
4/19/2025	1:00:00 AM	0.04
4/19/2025	1:15:00 AM	0.04
4/19/2025	1:30:00 AM	0.04
4/19/2025	1:45:00 AM	0.04
4/19/2025	2:00:00 AM	0.04
4/19/2025	2:15:00 AM	0.04
4/19/2025	2:30:00 AM	0.04
4/19/2025	2:45:00 AM	0.04
4/19/2025	3:00:00 AM	0.04
4/19/2025	3:15:00 AM	0.04
4/19/2025	3:30:00 AM	0.04
4/19/2025	3:45:00 AM	0.04
4/19/2025	4:00:00 AM	0.04
4/19/2025	4:15:00 AM	0.04
4/19/2025	4:30:00 AM	0.04
4/19/2025	4:45:00 AM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
4/19/2025	5:00:00 AM	0.04
4/19/2025	5:15:00 AM	0.04
4/19/2025	5:30:00 AM	0.04
4/19/2025	5:45:00 AM	0.04
4/19/2025	6:00:00 AM	0.04
4/19/2025	6:15:00 AM	0.04
4/19/2025	6:30:00 AM	0.04
4/19/2025	6:45:00 AM	0.04
4/19/2025	7:00:00 AM	0.04
4/19/2025	7:15:00 AM	0.04
4/19/2025	7:30:00 AM	0.04
4/19/2025	7:45:00 AM	0.04
4/19/2025	8:00:00 AM	0.04
4/19/2025	8:15:00 AM	0.04
4/19/2025	8:30:00 AM	0.05
4/19/2025	8:45:00 AM	0.05
4/19/2025	9:00:00 AM	0.05
4/19/2025	9:15:00 AM	0.05
4/19/2025	9:30:00 AM	0.05
4/19/2025	9:45:00 AM	0.05
4/19/2025	10:00:00 AM	0.05
4/19/2025	10:15:00 AM	0.05
4/19/2025	10:30:00 AM	0.05
4/19/2025	10:45:00 AM	0.05
4/19/2025	11:00:00 AM	0.05
4/19/2025	11:15:00 AM	0.05
4/19/2025	11:30:00 AM	0.05
4/19/2025	11:45:00 AM	0.05
4/19/2025	12:00:00 PM	0.05
4/19/2025	12:15:00 PM	0.06
4/19/2025	12:30:00 PM	0.06
4/19/2025	12:45:00 PM	0.06
4/19/2025	1:00:00 PM	0.06
4/19/2025	1:15:00 PM	0.06
4/19/2025	1:30:00 PM	0.06
4/19/2025	1:45:00 PM	0.06
4/19/2025	2:00:00 PM	0.06
4/19/2025	2:15:00 PM	0.06
4/19/2025	2:30:00 PM	0.06
4/19/2025	2:45:00 PM	0.06
4/19/2025	3:00:00 PM	0.06
4/19/2025	3:15:00 PM	0.06
4/19/2025	3:30:00 PM	0.06
4/19/2025	3:45:00 PM	0.06
4/19/2025	4:00:00 PM	0.06
4/19/2025	4:15:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
4/19/2025	4:30:00 PM	0.07
4/19/2025	4:45:00 PM	0.07
4/19/2025	5:00:00 PM	0.07
4/19/2025	5:15:00 PM	0.07
4/19/2025	5:30:00 PM	0.07
4/19/2025	5:45:00 PM	0.06
4/19/2025	6:00:00 PM	0.06
4/19/2025	6:15:00 PM	0.06
4/19/2025	6:30:00 PM	0.06
4/19/2025	6:45:00 PM	0.06
4/19/2025	7:00:00 PM	0.06
4/19/2025	7:15:00 PM	0.06
4/19/2025	7:30:00 PM	0.06
4/19/2025	7:45:00 PM	0.06
4/19/2025	8:00:00 PM	0.06
4/19/2025	8:15:00 PM	0.06
4/19/2025	8:30:00 PM	0.06
4/19/2025	8:45:00 PM	0.06
4/19/2025	9:00:00 PM	0.06
4/19/2025	9:15:00 PM	0.06
4/19/2025	9:30:00 PM	0.06
4/19/2025	9:45:00 PM	0.06
4/19/2025	10:00:00 PM	0.06
4/19/2025	10:15:00 PM	0.06
4/19/2025	10:30:00 PM	0.06
4/19/2025	10:45:00 PM	0.06
4/19/2025	11:00:00 PM	0.06
4/19/2025	11:15:00 PM	0.06
4/19/2025	11:30:00 PM	0.06
4/19/2025	11:45:00 PM	0.06
4/20/2025	12:00:00 AM	0.06
4/20/2025	12:15:00 AM	0.06
4/20/2025	12:30:00 AM	0.06
4/20/2025	12:45:00 AM	0.06
4/20/2025	1:00:00 AM	0.06
4/20/2025	1:15:00 AM	0.06
4/20/2025	1:30:00 AM	0.06
4/20/2025	1:45:00 AM	0.06
4/20/2025	2:00:00 AM	0.06
4/20/2025	2:15:00 AM	0.06
4/20/2025	2:30:00 AM	0.06
4/20/2025	2:45:00 AM	0.06
4/20/2025	3:00:00 AM	0.06
4/20/2025	3:15:00 AM	0.06
4/20/2025	3:30:00 AM	0.06
4/20/2025	3:45:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
4/20/2025	4:00:00 AM	0.06
4/20/2025	4:15:00 AM	0.06
4/20/2025	4:30:00 AM	0.06
4/20/2025	4:45:00 AM	0.06
4/20/2025	5:00:00 AM	0.06
4/20/2025	5:15:00 AM	0.06
4/20/2025	5:30:00 AM	0.06
4/20/2025	5:45:00 AM	0.06
4/20/2025	6:00:00 AM	0.06
4/20/2025	6:15:00 AM	0.06
4/20/2025	6:30:00 AM	0.06
4/20/2025	6:45:00 AM	0.06
4/20/2025	7:00:00 AM	0.06
4/20/2025	7:15:00 AM	0.06
4/20/2025	7:30:00 AM	0.06
4/20/2025	7:45:00 AM	0.06
4/20/2025	8:00:00 AM	0.06
4/20/2025	8:15:00 AM	0.06
4/20/2025	8:30:00 AM	0.06
4/20/2025	8:45:00 AM	0.06
4/20/2025	9:00:00 AM	0.06
4/20/2025	9:15:00 AM	0.06
4/20/2025	9:30:00 AM	0.06
4/20/2025	9:45:00 AM	0.06
4/20/2025	10:00:00 AM	0.06
4/20/2025	10:15:00 AM	0.06
4/20/2025	10:30:00 AM	0.06
4/20/2025	10:45:00 AM	0.06
4/20/2025	11:00:00 AM	0.06
4/20/2025	11:15:00 AM	0.06
4/20/2025	11:30:00 AM	0.06
4/20/2025	11:45:00 AM	0.06
4/20/2025	12:00:00 PM	0.06
4/20/2025	12:15:00 PM	0.06
4/20/2025	12:30:00 PM	0.06
4/20/2025	12:45:00 PM	0.06
4/20/2025	1:00:00 PM	0.06
4/20/2025	1:15:00 PM	0.06
4/20/2025	1:30:00 PM	0.06
4/20/2025	1:45:00 PM	0.06
4/20/2025	2:00:00 PM	0.06
4/20/2025	2:15:00 PM	0.06
4/20/2025	2:30:00 PM	0.06
4/20/2025	2:45:00 PM	0.06
4/20/2025	3:00:00 PM	0.06
4/20/2025	3:15:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
4/20/2025	3:30:00 PM	0.06
4/20/2025	3:45:00 PM	0.06
4/20/2025	4:00:00 PM	0.06
4/20/2025	4:15:00 PM	0.06
4/20/2025	4:30:00 PM	0.06
4/20/2025	4:45:00 PM	0.06
4/20/2025	5:00:00 PM	0.06
4/20/2025	5:15:00 PM	0.06
4/20/2025	5:30:00 PM	0.06
4/20/2025	5:45:00 PM	0.06
4/20/2025	6:00:00 PM	0.06
4/20/2025	6:15:00 PM	0.06
4/20/2025	6:30:00 PM	0.06
4/20/2025	6:45:00 PM	0.06
4/20/2025	7:00:00 PM	0.06
4/20/2025	7:15:00 PM	0.07
4/20/2025	7:30:00 PM	0.07
4/20/2025	7:45:00 PM	0.07
4/20/2025	8:00:00 PM	0.07
4/20/2025	8:15:00 PM	0.07
4/20/2025	8:30:00 PM	0.07
4/20/2025	8:45:00 PM	0.07
4/20/2025	9:00:00 PM	0.07
4/20/2025	9:15:00 PM	0.07
4/20/2025	9:30:00 PM	0.07
4/20/2025	9:45:00 PM	0.07
4/20/2025	10:00:00 PM	0.07
4/20/2025	10:15:00 PM	0.07
4/20/2025	10:30:00 PM	0.07
4/20/2025	10:45:00 PM	0.07
4/20/2025	11:00:00 PM	0.07
4/20/2025	11:15:00 PM	0.07
4/20/2025	11:30:00 PM	0.07
4/20/2025	11:45:00 PM	0.07
4/21/2025	12:00:00 AM	0.07
4/21/2025	12:15:00 AM	0.07
4/21/2025	12:30:00 AM	0.07
4/21/2025	12:45:00 AM	0.07
4/21/2025	1:00:00 AM	0.07
4/21/2025	1:15:00 AM	0.07
4/21/2025	1:30:00 AM	0.07
4/21/2025	1:45:00 AM	0.07
4/21/2025	2:00:00 AM	0.07
4/21/2025	2:15:00 AM	0.07
4/21/2025	2:30:00 AM	0.07
4/21/2025	2:45:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
4/21/2025	3:00:00 AM	0.07
4/21/2025	3:15:00 AM	0.07
4/21/2025	3:30:00 AM	0.07
4/21/2025	3:45:00 AM	0.07
4/21/2025	4:00:00 AM	0.07
4/21/2025	4:15:00 AM	0.07
4/21/2025	4:30:00 AM	0.07
4/21/2025	4:45:00 AM	0.07
4/21/2025	5:00:00 AM	0.07
4/21/2025	5:15:00 AM	0.07
4/21/2025	5:30:00 AM	0.07
4/21/2025	5:45:00 AM	0.07
4/21/2025	6:00:00 AM	0.07
4/21/2025	6:15:00 AM	0.07
4/21/2025	6:30:00 AM	0.07
4/21/2025	6:45:00 AM	0.07
4/21/2025	7:00:00 AM	0.07
4/21/2025	7:15:00 AM	0.07
4/21/2025	7:30:00 AM	0.07
4/21/2025	7:45:00 AM	0.07
4/21/2025	8:00:00 AM	0.07
4/21/2025	8:15:00 AM	0.07
4/21/2025	8:30:00 AM	0.07
4/21/2025	8:45:00 AM	0.07
4/21/2025	9:00:00 AM	0.07
4/21/2025	9:15:00 AM	0.07
4/21/2025	9:30:00 AM	0.06
4/21/2025	9:45:00 AM	0.06
4/21/2025	10:00:00 AM	0.06
4/21/2025	10:15:00 AM	0.06
4/21/2025	10:30:00 AM	0.06
4/21/2025	10:45:00 AM	0.06
4/21/2025	11:00:00 AM	0.06
4/21/2025	11:15:00 AM	0.06
4/21/2025	11:30:00 AM	0.06
4/21/2025	11:45:00 AM	0.06
4/21/2025	12:00:00 PM	0.06
4/21/2025	12:15:00 PM	0.06
4/21/2025	12:30:00 PM	0.06
4/21/2025	12:45:00 PM	0.06
4/21/2025	1:00:00 PM	0.06
4/21/2025	1:15:00 PM	0.06
4/21/2025	1:30:00 PM	0.06
4/21/2025	1:45:00 PM	0.06
4/21/2025	2:00:00 PM	0.06
4/21/2025	2:15:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
4/21/2025	2:30:00 PM	0.06
4/21/2025	2:45:00 PM	0.06
4/21/2025	3:00:00 PM	0.06
4/21/2025	3:15:00 PM	0.06
4/21/2025	3:30:00 PM	0.06
4/21/2025	3:45:00 PM	0.06
4/21/2025	4:00:00 PM	0.06
4/21/2025	4:15:00 PM	0.06
4/21/2025	4:30:00 PM	0.06
4/21/2025	4:45:00 PM	0.06
4/21/2025	5:00:00 PM	0.06
4/21/2025	5:15:00 PM	0.06
4/21/2025	5:30:00 PM	0.06
4/21/2025	5:45:00 PM	0.06
4/21/2025	6:00:00 PM	0.06
4/21/2025	6:15:00 PM	0.06
4/21/2025	6:30:00 PM	0.06
4/21/2025	6:45:00 PM	0.06
4/21/2025	7:00:00 PM	0.06
4/21/2025	7:15:00 PM	0.06
4/21/2025	7:30:00 PM	0.06
4/21/2025	7:45:00 PM	0.06
4/21/2025	8:00:00 PM	0.06
4/21/2025	8:15:00 PM	0.06
4/21/2025	8:30:00 PM	0.06
4/21/2025	8:45:00 PM	0.06
4/21/2025	9:00:00 PM	0.06
4/21/2025	9:15:00 PM	0.06
4/21/2025	9:30:00 PM	0.06
4/21/2025	9:45:00 PM	0.06
4/21/2025	10:00:00 PM	0.06
4/21/2025	10:15:00 PM	0.06
4/21/2025	10:30:00 PM	0.06
4/21/2025	10:45:00 PM	0.06
4/21/2025	11:00:00 PM	0.06
4/21/2025	11:15:00 PM	0.06
4/21/2025	11:30:00 PM	0.06
4/21/2025	11:45:00 PM	0.06
4/22/2025	12:00:00 AM	0.06
4/22/2025	12:15:00 AM	0.06
4/22/2025	12:30:00 AM	0.06
4/22/2025	12:45:00 AM	0.06
4/22/2025	1:00:00 AM	0.06
4/22/2025	1:15:00 AM	0.06
4/22/2025	1:30:00 AM	0.06
4/22/2025	1:45:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
4/22/2025	2:00:00 AM	0.06
4/22/2025	2:15:00 AM	0.06
4/22/2025	2:30:00 AM	0.06
4/22/2025	2:45:00 AM	0.06
4/22/2025	3:00:00 AM	0.06
4/22/2025	3:15:00 AM	0.06
4/22/2025	3:30:00 AM	0.06
4/22/2025	3:45:00 AM	0.06
4/22/2025	4:00:00 AM	0.06
4/22/2025	4:15:00 AM	0.06
4/22/2025	4:30:00 AM	0.06
4/22/2025	4:45:00 AM	0.06
4/22/2025	5:00:00 AM	0.06
4/22/2025	5:15:00 AM	0.06
4/22/2025	5:30:00 AM	0.06
4/22/2025	5:45:00 AM	0.06
4/22/2025	6:00:00 AM	0.06
4/22/2025	6:15:00 AM	0.06
4/22/2025	6:30:00 AM	0.06
4/22/2025	6:45:00 AM	0.06
4/22/2025	7:00:00 AM	0.06
4/22/2025	7:15:00 AM	0.05
4/22/2025	7:30:00 AM	0.05
4/22/2025	7:45:00 AM	0.05
4/22/2025	8:00:00 AM	0.05
4/22/2025	8:15:00 AM	0.05
4/22/2025	8:30:00 AM	0.05
4/22/2025	8:45:00 AM	0.05
4/22/2025	9:00:00 AM	0.05
4/22/2025	9:15:00 AM	0.05
4/22/2025	9:30:00 AM	0.05
4/22/2025	9:45:00 AM	0.05
4/22/2025	10:00:00 AM	0.05
4/22/2025	10:15:00 AM	0.05
4/22/2025	10:30:00 AM	0.05
4/22/2025	10:45:00 AM	0.05
4/22/2025	11:00:00 AM	0.05
4/22/2025	11:15:00 AM	0.05
4/22/2025	11:30:00 AM	0.05
4/22/2025	11:45:00 AM	0.05
4/22/2025	12:00:00 PM	0.05
4/22/2025	12:15:00 PM	0.05
4/22/2025	12:30:00 PM	0.05
4/22/2025	12:45:00 PM	0.05
4/22/2025	1:00:00 PM	0.05
4/22/2025	1:15:00 PM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
4/22/2025	1:30:00 PM	0.05
4/22/2025	1:45:00 PM	0.05
4/22/2025	2:00:00 PM	0.05
4/22/2025	2:15:00 PM	0.05
4/22/2025	2:30:00 PM	0.05
4/22/2025	2:45:00 PM	0.05
4/22/2025	3:00:00 PM	0.05
4/22/2025	3:15:00 PM	0.05
4/22/2025	3:30:00 PM	0.05
4/22/2025	3:45:00 PM	0.05
4/22/2025	4:00:00 PM	0.05
4/22/2025	4:15:00 PM	0.05
4/22/2025	4:30:00 PM	0.05
4/22/2025	4:45:00 PM	0.05
4/22/2025	5:00:00 PM	0.05
4/22/2025	5:15:00 PM	0.05
4/22/2025	5:30:00 PM	0.05
4/22/2025	5:45:00 PM	0.05
4/22/2025	6:00:00 PM	0.05
4/22/2025	6:15:00 PM	0.05
4/22/2025	6:30:00 PM	0.06
4/22/2025	6:45:00 PM	0.06
4/22/2025	7:00:00 PM	0.06
4/22/2025	7:15:00 PM	0.06
4/22/2025	7:30:00 PM	0.06
4/22/2025	7:45:00 PM	0.06
4/22/2025	8:00:00 PM	0.06
4/22/2025	8:15:00 PM	0.06
4/22/2025	8:30:00 PM	0.06
4/22/2025	8:45:00 PM	0.06
4/22/2025	9:00:00 PM	0.06
4/22/2025	9:15:00 PM	0.06
4/22/2025	9:30:00 PM	0.06
4/22/2025	9:45:00 PM	0.06
4/22/2025	10:00:00 PM	0.06
4/22/2025	10:15:00 PM	0.06
4/22/2025	10:30:00 PM	0.06
4/22/2025	10:45:00 PM	0.06
4/22/2025	11:00:00 PM	0.06
4/22/2025	11:15:00 PM	0.06
4/22/2025	11:30:00 PM	0.06
4/22/2025	11:45:00 PM	0.06
4/23/2025	12:00:00 AM	0.06
4/23/2025	12:15:00 AM	0.07
4/23/2025	12:30:00 AM	0.07
4/23/2025	12:45:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
4/23/2025	1:00:00 AM	0.07
4/23/2025	1:15:00 AM	0.07
4/23/2025	1:30:00 AM	0.07
4/23/2025	1:45:00 AM	0.07
4/23/2025	2:00:00 AM	0.07
4/23/2025	2:15:00 AM	0.07
4/23/2025	2:30:00 AM	0.07
4/23/2025	2:45:00 AM	0.07
4/23/2025	3:00:00 AM	0.07
4/23/2025	3:15:00 AM	0.07
4/23/2025	3:30:00 AM	0.07
4/23/2025	3:45:00 AM	0.07
4/23/2025	4:00:00 AM	0.07
4/23/2025	4:15:00 AM	0.07
4/23/2025	4:30:00 AM	0.07
4/23/2025	4:45:00 AM	0.07
4/23/2025	5:00:00 AM	0.07
4/23/2025	5:15:00 AM	0.07
4/23/2025	5:30:00 AM	0.07
4/23/2025	5:45:00 AM	0.08
4/23/2025	6:00:00 AM	0.07
4/23/2025	6:15:00 AM	0.07
4/23/2025	6:30:00 AM	0.07
4/23/2025	6:45:00 AM	0.07
4/23/2025	7:00:00 AM	0.07
4/23/2025	7:15:00 AM	0.07
4/23/2025	7:30:00 AM	0.07
4/23/2025	7:45:00 AM	0.07
4/23/2025	8:00:00 AM	0.07
4/23/2025	8:15:00 AM	0.07
4/23/2025	8:30:00 AM	0.07
4/23/2025	8:45:00 AM	0.07
4/23/2025	9:00:00 AM	0.07
4/23/2025	9:15:00 AM	0.07
4/23/2025	9:30:00 AM	0.07
4/23/2025	9:45:00 AM	0.07
4/23/2025	10:00:00 AM	0.06
4/23/2025	10:15:00 AM	0.06
4/23/2025	10:30:00 AM	0.07
4/23/2025	10:45:00 AM	0.07
4/23/2025	11:00:00 AM	0.07
4/23/2025	11:15:00 AM	0.07
4/23/2025	11:30:00 AM	0.07
4/23/2025	11:45:00 AM	0.07
4/23/2025	12:00:00 PM	0.07
4/23/2025	12:15:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
4/23/2025	12:30:00 PM	0.07
4/23/2025	12:45:00 PM	0.07
4/23/2025	1:00:00 PM	0.06
4/23/2025	1:15:00 PM	0.06
4/23/2025	1:30:00 PM	0.06
4/23/2025	1:45:00 PM	0.06
4/23/2025	2:00:00 PM	0.06
4/23/2025	2:15:00 PM	0.06
4/23/2025	2:30:00 PM	0.07
4/23/2025	2:45:00 PM	0.07
4/23/2025	3:00:00 PM	0.07
4/23/2025	3:15:00 PM	0.07
4/23/2025	3:30:00 PM	0.07
4/23/2025	3:45:00 PM	0.07
4/23/2025	4:00:00 PM	0.07
4/23/2025	4:15:00 PM	0.07
4/23/2025	4:30:00 PM	0.08
4/23/2025	4:45:00 PM	0.08
4/23/2025	5:00:00 PM	0.08
4/23/2025	5:15:00 PM	0.09
4/23/2025	5:30:00 PM	0.09
4/23/2025	5:45:00 PM	0.09
4/23/2025	6:00:00 PM	0.09
4/23/2025	6:15:00 PM	0.09
4/23/2025	6:30:00 PM	0.09
4/23/2025	6:45:00 PM	0.09
4/23/2025	7:00:00 PM	0.09
4/23/2025	7:15:00 PM	0.09
4/23/2025	7:30:00 PM	0.09
4/23/2025	7:45:00 PM	0.09
4/23/2025	8:00:00 PM	0.09
4/23/2025	8:15:00 PM	0.09
4/23/2025	8:30:00 PM	0.09
4/23/2025	8:45:00 PM	0.09
4/23/2025	9:00:00 PM	0.09
4/23/2025	9:15:00 PM	0.09
4/23/2025	9:30:00 PM	0.09
4/23/2025	9:45:00 PM	0.09
4/23/2025	10:00:00 PM	0.09
4/23/2025	10:15:00 PM	0.09
4/23/2025	10:30:00 PM	0.09
4/23/2025	10:45:00 PM	0.09
4/23/2025	11:00:00 PM	0.09
4/23/2025	11:15:00 PM	0.08
4/23/2025	11:30:00 PM	0.08
4/23/2025	11:45:00 PM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
4/24/2025	12:00:00 AM	0.08
4/24/2025	12:15:00 AM	0.08
4/24/2025	12:30:00 AM	0.08
4/24/2025	12:45:00 AM	0.08
4/24/2025	1:00:00 AM	0.08
4/24/2025	1:15:00 AM	0.08
4/24/2025	1:30:00 AM	0.08
4/24/2025	1:45:00 AM	0.08
4/24/2025	2:00:00 AM	0.08
4/24/2025	2:15:00 AM	0.08
4/24/2025	2:30:00 AM	0.08
4/24/2025	2:45:00 AM	0.08
4/24/2025	3:00:00 AM	0.08
4/24/2025	3:15:00 AM	0.08
4/24/2025	3:30:00 AM	0.08
4/24/2025	3:45:00 AM	0.08
4/24/2025	4:00:00 AM	0.08
4/24/2025	4:15:00 AM	0.08
4/24/2025	4:30:00 AM	0.08
4/24/2025	4:45:00 AM	0.08
4/24/2025	5:00:00 AM	0.08
4/24/2025	5:15:00 AM	0.08
4/24/2025	5:30:00 AM	0.08
4/24/2025	5:45:00 AM	0.08
4/24/2025	6:00:00 AM	0.08
4/24/2025	6:15:00 AM	0.08
4/24/2025	6:30:00 AM	0.08
4/24/2025	6:45:00 AM	0.08
4/24/2025	7:00:00 AM	0.08
4/24/2025	7:15:00 AM	0.08
4/24/2025	7:30:00 AM	0.08
4/24/2025	7:45:00 AM	0.08
4/24/2025	8:00:00 AM	0.08
4/24/2025	8:15:00 AM	0.09
4/24/2025	8:30:00 AM	0.09
4/24/2025	8:45:00 AM	0.09
4/24/2025	9:00:00 AM	0.09
4/24/2025	9:15:00 AM	0.09
4/24/2025	9:30:00 AM	0.09
4/24/2025	9:45:00 AM	0.08
4/24/2025	10:00:00 AM	0.08
4/24/2025	10:15:00 AM	0.08
4/24/2025	10:30:00 AM	0.08
4/24/2025	10:45:00 AM	0.07
4/24/2025	11:00:00 AM	0.07
4/24/2025	11:15:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
4/24/2025	11:30:00 AM	0.06
4/24/2025	11:45:00 AM	0.06
4/24/2025	12:00:00 PM	0.06
4/24/2025	12:15:00 PM	0.05
4/24/2025	12:30:00 PM	0.05
4/24/2025	12:45:00 PM	0.05
4/24/2025	1:00:00 PM	0.05
4/24/2025	1:15:00 PM	0.05
4/24/2025	1:30:00 PM	0.05
4/24/2025	1:45:00 PM	0.05
4/24/2025	2:00:00 PM	0.06
4/24/2025	2:15:00 PM	0.07
4/24/2025	2:30:00 PM	0.07
4/24/2025	2:45:00 PM	0.07
4/24/2025	3:00:00 PM	0.08
4/24/2025	3:15:00 PM	0.08
4/24/2025	3:30:00 PM	0.08
4/24/2025	3:45:00 PM	0.08
4/24/2025	4:00:00 PM	0.08
4/24/2025	4:15:00 PM	0.08
4/24/2025	4:30:00 PM	0.08
4/24/2025	4:45:00 PM	0.08
4/24/2025	5:00:00 PM	0.08
4/24/2025	5:15:00 PM	0.08
4/24/2025	5:30:00 PM	0.08
4/24/2025	5:45:00 PM	0.08
4/24/2025	6:00:00 PM	0.08
4/24/2025	6:15:00 PM	0.08
4/24/2025	6:30:00 PM	0.08
4/24/2025	6:45:00 PM	0.08
4/24/2025	7:00:00 PM	0.08
4/24/2025	7:15:00 PM	0.08
4/24/2025	7:30:00 PM	0.08
4/24/2025	7:45:00 PM	0.08
4/24/2025	8:00:00 PM	0.08
4/24/2025	8:15:00 PM	0.09
4/24/2025	8:30:00 PM	0.08
4/24/2025	8:45:00 PM	0.08
4/24/2025	9:00:00 PM	0.08
4/24/2025	9:15:00 PM	0.08
4/24/2025	9:30:00 PM	0.08
4/24/2025	9:45:00 PM	0.08
4/24/2025	10:00:00 PM	0.08
4/24/2025	10:15:00 PM	0.09
4/24/2025	10:30:00 PM	0.09
4/24/2025	10:45:00 PM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
4/24/2025	11:00:00 PM	0.09
4/24/2025	11:15:00 PM	0.09
4/24/2025	11:30:00 PM	0.09
4/24/2025	11:45:00 PM	0.09
4/25/2025	12:00:00 AM	0.09
4/25/2025	12:15:00 AM	0.09
4/25/2025	12:30:00 AM	0.09
4/25/2025	12:45:00 AM	0.09
4/25/2025	1:00:00 AM	0.09
4/25/2025	1:15:00 AM	0.09
4/25/2025	1:30:00 AM	0.09
4/25/2025	1:45:00 AM	0.09
4/25/2025	2:00:00 AM	0.09
4/25/2025	2:15:00 AM	0.09
4/25/2025	2:30:00 AM	0.09
4/25/2025	2:45:00 AM	0.09
4/25/2025	3:00:00 AM	0.09
4/25/2025	3:15:00 AM	0.09
4/25/2025	3:30:00 AM	0.09
4/25/2025	3:45:00 AM	0.09
4/25/2025	4:00:00 AM	0.09
4/25/2025	4:15:00 AM	0.09
4/25/2025	4:30:00 AM	0.09
4/25/2025	4:45:00 AM	0.09
4/25/2025	5:00:00 AM	0.09
4/25/2025	5:15:00 AM	0.09
4/25/2025	5:30:00 AM	0.09
4/25/2025	5:45:00 AM	0.09
4/25/2025	6:00:00 AM	0.08
4/25/2025	6:15:00 AM	0.08
4/25/2025	6:30:00 AM	0.08
4/25/2025	6:45:00 AM	0.08
4/25/2025	7:00:00 AM	0.08
4/25/2025	7:15:00 AM	0.08
4/25/2025	7:30:00 AM	0.08
4/25/2025	7:45:00 AM	0.08
4/25/2025	8:00:00 AM	0.08
4/25/2025	8:15:00 AM	0.08
4/25/2025	8:30:00 AM	0.08
4/25/2025	8:45:00 AM	0.08
4/25/2025	9:00:00 AM	0.08
4/25/2025	9:15:00 AM	0.08
4/25/2025	9:30:00 AM	0.08
4/25/2025	9:45:00 AM	0.08
4/25/2025	10:00:00 AM	0.07
4/25/2025	10:15:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
4/25/2025	10:30:00 AM	0.07
4/25/2025	10:45:00 AM	0.07
4/25/2025	11:00:00 AM	0.07
4/25/2025	11:15:00 AM	0.07
4/25/2025	11:30:00 AM	0.07
4/25/2025	11:45:00 AM	0.07
4/25/2025	12:00:00 PM	0.07
4/25/2025	12:15:00 PM	0.07
4/25/2025	12:30:00 PM	0.07
4/25/2025	12:45:00 PM	0.07
4/25/2025	1:00:00 PM	0.07
4/25/2025	1:15:00 PM	0.07
4/25/2025	1:30:00 PM	0.06
4/25/2025	1:45:00 PM	0.06
4/25/2025	2:00:00 PM	0.06
4/25/2025	2:15:00 PM	0.06
4/25/2025	2:30:00 PM	0.06
4/25/2025	2:45:00 PM	0.06
4/25/2025	3:00:00 PM	0.06
4/25/2025	3:15:00 PM	0.06
4/25/2025	3:30:00 PM	0.06
4/25/2025	3:45:00 PM	0.06
4/25/2025	4:00:00 PM	0.06
4/25/2025	4:15:00 PM	0.06
4/25/2025	4:30:00 PM	0.06
4/25/2025	4:45:00 PM	0.06
4/25/2025	5:00:00 PM	0.06
4/25/2025	5:15:00 PM	0.06
4/25/2025	5:30:00 PM	0.06
4/25/2025	5:45:00 PM	0.06
4/25/2025	6:00:00 PM	0.06
4/25/2025	6:15:00 PM	0.06
4/25/2025	6:30:00 PM	0.06
4/25/2025	6:45:00 PM	0.07
4/25/2025	7:00:00 PM	0.06
4/25/2025	7:15:00 PM	0.06
4/25/2025	7:30:00 PM	0.07
4/25/2025	7:45:00 PM	0.07
4/25/2025	8:00:00 PM	0.07
4/25/2025	8:15:00 PM	0.07
4/25/2025	8:30:00 PM	0.07
4/25/2025	8:45:00 PM	0.07
4/25/2025	9:00:00 PM	0.07
4/25/2025	9:15:00 PM	0.07
4/25/2025	9:30:00 PM	0.07
4/25/2025	9:45:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
4/25/2025	10:00:00 PM	0.07
4/25/2025	10:15:00 PM	0.07
4/25/2025	10:30:00 PM	0.07
4/25/2025	10:45:00 PM	0.07
4/25/2025	11:00:00 PM	0.07
4/25/2025	11:15:00 PM	0.07
4/25/2025	11:30:00 PM	0.07
4/25/2025	11:45:00 PM	0.07
4/26/2025	12:00:00 AM	0.07
4/26/2025	12:15:00 AM	0.07
4/26/2025	12:30:00 AM	0.07
4/26/2025	12:45:00 AM	0.07
4/26/2025	1:00:00 AM	0.07
4/26/2025	1:15:00 AM	0.07
4/26/2025	1:30:00 AM	0.06
4/26/2025	1:45:00 AM	0.06
4/26/2025	2:00:00 AM	0.06
4/26/2025	2:15:00 AM	0.06
4/26/2025	2:30:00 AM	0.06
4/26/2025	2:45:00 AM	0.06
4/26/2025	3:00:00 AM	0.06
4/26/2025	3:15:00 AM	0.06
4/26/2025	3:30:00 AM	0.06
4/26/2025	3:45:00 AM	0.06
4/26/2025	4:00:00 AM	0.06
4/26/2025	4:15:00 AM	0.06
4/26/2025	4:30:00 AM	0.06
4/26/2025	4:45:00 AM	0.06
4/26/2025	5:00:00 AM	0.06
4/26/2025	5:15:00 AM	0.06
4/26/2025	5:30:00 AM	0.06
4/26/2025	5:45:00 AM	0.06
4/26/2025	6:00:00 AM	0.06
4/26/2025	6:15:00 AM	0.06
4/26/2025	6:30:00 AM	0.06
4/26/2025	6:45:00 AM	0.06
4/26/2025	7:00:00 AM	0.06
4/26/2025	7:15:00 AM	0.06
4/26/2025	7:30:00 AM	0.06
4/26/2025	7:45:00 AM	0.06
4/26/2025	8:00:00 AM	0.06
4/26/2025	8:15:00 AM	0.06
4/26/2025	8:30:00 AM	0.06
4/26/2025	8:45:00 AM	0.06
4/26/2025	9:00:00 AM	0.05
4/26/2025	9:15:00 AM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
4/26/2025	9:30:00 AM	0.05
4/26/2025	9:45:00 AM	0.05
4/26/2025	10:00:00 AM	0.05
4/26/2025	10:15:00 AM	0.05
4/26/2025	10:30:00 AM	0.05
4/26/2025	10:45:00 AM	0.05
4/26/2025	11:00:00 AM	0.05
4/26/2025	11:15:00 AM	0.05
4/26/2025	11:30:00 AM	0.05
4/26/2025	11:45:00 AM	0.05
4/26/2025	12:00:00 PM	0.05
4/26/2025	12:15:00 PM	0.05
4/26/2025	12:30:00 PM	0.05
4/26/2025	12:45:00 PM	0.05
4/26/2025	1:00:00 PM	0.05
4/26/2025	1:15:00 PM	0.05
4/26/2025	1:30:00 PM	0.05
4/26/2025	1:45:00 PM	0.05
4/26/2025	2:00:00 PM	0.05
4/26/2025	2:15:00 PM	0.05
4/26/2025	2:30:00 PM	0.05
4/26/2025	2:45:00 PM	0.05
4/26/2025	3:00:00 PM	0.05
4/26/2025	3:15:00 PM	0.05
4/26/2025	3:30:00 PM	0.05
4/26/2025	3:45:00 PM	0.05
4/26/2025	4:00:00 PM	0.05
4/26/2025	4:15:00 PM	0.05
4/26/2025	4:30:00 PM	0.05
4/26/2025	4:45:00 PM	0.05
4/26/2025	5:00:00 PM	0.05
4/26/2025	5:15:00 PM	0.05
4/26/2025	5:30:00 PM	0.05
4/26/2025	5:45:00 PM	0.05
4/26/2025	6:00:00 PM	0.05
4/26/2025	6:15:00 PM	0.05
4/26/2025	6:30:00 PM	0.05
4/26/2025	6:45:00 PM	0.05
4/26/2025	7:00:00 PM	0.05
4/26/2025	7:15:00 PM	0.05
4/26/2025	7:30:00 PM	0.05
4/26/2025	7:45:00 PM	0.04
4/26/2025	8:00:00 PM	0.04
4/26/2025	8:15:00 PM	0.04
4/26/2025	8:30:00 PM	0.04
4/26/2025	8:45:00 PM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
4/26/2025	9:00:00 PM	0.04
4/26/2025	9:15:00 PM	0.04
4/26/2025	9:30:00 PM	0.04
4/26/2025	9:45:00 PM	0.04
4/26/2025	10:00:00 PM	0.04
4/26/2025	10:15:00 PM	0.04
4/26/2025	10:30:00 PM	0.04
4/26/2025	10:45:00 PM	0.04
4/26/2025	11:00:00 PM	0.04
4/26/2025	11:15:00 PM	0.04
4/26/2025	11:30:00 PM	0.04
4/26/2025	11:45:00 PM	0.04
4/27/2025	12:00:00 AM	0.04
4/27/2025	12:15:00 AM	0.04
4/27/2025	12:30:00 AM	0.04
4/27/2025	12:45:00 AM	0.04
4/27/2025	1:00:00 AM	0.04
4/27/2025	1:15:00 AM	0.04
4/27/2025	1:30:00 AM	0.04
4/27/2025	1:45:00 AM	0.04
4/27/2025	2:00:00 AM	0.04
4/27/2025	2:15:00 AM	0.04
4/27/2025	2:30:00 AM	0.04
4/27/2025	2:45:00 AM	0.04
4/27/2025	3:00:00 AM	0.04
4/27/2025	3:15:00 AM	0.04
4/27/2025	3:30:00 AM	0.04
4/27/2025	3:45:00 AM	0.04
4/27/2025	4:00:00 AM	0.04
4/27/2025	4:15:00 AM	0.04
4/27/2025	4:30:00 AM	0.04
4/27/2025	4:45:00 AM	0.04
4/27/2025	5:00:00 AM	0.04
4/27/2025	5:15:00 AM	0.04
4/27/2025	5:30:00 AM	0.04
4/27/2025	5:45:00 AM	0.04
4/27/2025	6:00:00 AM	0.04
4/27/2025	6:15:00 AM	0.04
4/27/2025	6:30:00 AM	0.04
4/27/2025	6:45:00 AM	0.04
4/27/2025	7:00:00 AM	0.04
4/27/2025	7:15:00 AM	0.04
4/27/2025	7:30:00 AM	0.04
4/27/2025	7:45:00 AM	0.04
4/27/2025	8:00:00 AM	0.04
4/27/2025	8:15:00 AM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
4/27/2025	8:30:00 AM	0.04
4/27/2025	8:45:00 AM	0.04
4/27/2025	9:00:00 AM	0.04
4/27/2025	9:15:00 AM	0.04
4/27/2025	9:30:00 AM	0.04
4/27/2025	9:45:00 AM	0.04
4/27/2025	10:00:00 AM	0.04
4/27/2025	10:15:00 AM	0.03
4/27/2025	10:30:00 AM	0.03
4/27/2025	10:45:00 AM	0.03
4/27/2025	11:00:00 AM	0.03
4/27/2025	11:15:00 AM	0.03
4/27/2025	11:30:00 AM	0.03
4/27/2025	11:45:00 AM	0.03
4/27/2025	12:00:00 PM	0.03
4/27/2025	12:15:00 PM	0.03
4/27/2025	12:30:00 PM	0.03
4/27/2025	12:45:00 PM	0.03
4/27/2025	1:00:00 PM	0.03
4/27/2025	1:15:00 PM	0.04
4/27/2025	1:30:00 PM	0.04
4/27/2025	1:45:00 PM	0.04
4/27/2025	2:00:00 PM	0.03
4/27/2025	2:15:00 PM	0.03
4/27/2025	2:30:00 PM	0.03
4/27/2025	2:45:00 PM	0.03
4/27/2025	3:00:00 PM	0.03
4/27/2025	3:15:00 PM	0.03
4/27/2025	3:30:00 PM	0.03
4/27/2025	3:45:00 PM	0.03
4/27/2025	4:00:00 PM	0.03
4/27/2025	4:15:00 PM	0.03
4/27/2025	4:30:00 PM	0.03
4/27/2025	4:45:00 PM	0.04
4/27/2025	5:00:00 PM	0.04
4/27/2025	5:15:00 PM	0.04
4/27/2025	5:30:00 PM	0.04
4/27/2025	5:45:00 PM	0.04
4/27/2025	6:00:00 PM	0.04
4/27/2025	6:15:00 PM	0.04
4/27/2025	6:30:00 PM	0.04
4/27/2025	6:45:00 PM	0.04
4/27/2025	7:00:00 PM	0.04
4/27/2025	7:15:00 PM	0.04
4/27/2025	7:30:00 PM	0.04
4/27/2025	7:45:00 PM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
4/27/2025	8:00:00 PM	0.04
4/27/2025	8:15:00 PM	0.05
4/27/2025	8:30:00 PM	0.05
4/27/2025	8:45:00 PM	0.05
4/27/2025	9:00:00 PM	0.05
4/27/2025	9:15:00 PM	0.05
4/27/2025	9:30:00 PM	0.05
4/27/2025	9:45:00 PM	0.05
4/27/2025	10:00:00 PM	0.05
4/27/2025	10:15:00 PM	0.05
4/27/2025	10:30:00 PM	0.05
4/27/2025	10:45:00 PM	0.05
4/27/2025	11:00:00 PM	0.05
4/27/2025	11:15:00 PM	0.06
4/27/2025	11:30:00 PM	0.06
4/27/2025	11:45:00 PM	0.06
4/28/2025	12:00:00 AM	0.06
4/28/2025	12:15:00 AM	0.06
4/28/2025	12:30:00 AM	0.06
4/28/2025	12:45:00 AM	0.06
4/28/2025	1:00:00 AM	0.06
4/28/2025	1:15:00 AM	0.06
4/28/2025	1:30:00 AM	0.06
4/28/2025	1:45:00 AM	0.06
4/28/2025	2:00:00 AM	0.06
4/28/2025	2:15:00 AM	0.06
4/28/2025	2:30:00 AM	0.06
4/28/2025	2:45:00 AM	0.06
4/28/2025	3:00:00 AM	0.06
4/28/2025	3:15:00 AM	0.06
4/28/2025	3:30:00 AM	0.06
4/28/2025	3:45:00 AM	0.06
4/28/2025	4:00:00 AM	0.06
4/28/2025	4:15:00 AM	0.06
4/28/2025	4:30:00 AM	0.06
4/28/2025	4:45:00 AM	0.06
4/28/2025	5:00:00 AM	0.06
4/28/2025	5:15:00 AM	0.06
4/28/2025	5:30:00 AM	0.06
4/28/2025	5:45:00 AM	0.06
4/28/2025	6:00:00 AM	0.06
4/28/2025	6:15:00 AM	0.06
4/28/2025	6:30:00 AM	0.06
4/28/2025	6:45:00 AM	0.06
4/28/2025	7:00:00 AM	0.06
4/28/2025	7:15:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
4/28/2025	7:30:00 AM	0.06
4/28/2025	7:45:00 AM	0.06
4/28/2025	8:00:00 AM	0.06
4/28/2025	8:15:00 AM	0.06
4/28/2025	8:30:00 AM	0.06
4/28/2025	8:45:00 AM	0.06
4/28/2025	9:00:00 AM	0.06
4/28/2025	9:15:00 AM	0.06
4/28/2025	9:30:00 AM	0.06
4/28/2025	9:45:00 AM	0.05
4/28/2025	10:00:00 AM	0.05
4/28/2025	10:15:00 AM	0.05
4/28/2025	10:30:00 AM	0.05
4/28/2025	10:45:00 AM	0.05
4/28/2025	11:00:00 AM	0.05
4/28/2025	11:15:00 AM	0.06
4/28/2025	11:30:00 AM	0.05
4/28/2025	11:45:00 AM	0.05
4/28/2025	12:00:00 PM	0.05
4/28/2025	12:15:00 PM	0.05
4/28/2025	12:30:00 PM	0.05
4/28/2025	12:45:00 PM	0.05
4/28/2025	1:00:00 PM	0.05
4/28/2025	1:15:00 PM	0.05
4/28/2025	1:30:00 PM	0.05
4/28/2025	1:45:00 PM	0.05
4/28/2025	2:00:00 PM	0.05
4/28/2025	2:15:00 PM	0.05
4/28/2025	2:30:00 PM	0.05
4/28/2025	2:45:00 PM	0.05
4/28/2025	3:00:00 PM	0.05
4/28/2025	3:15:00 PM	0.05
4/28/2025	3:30:00 PM	0.04
4/28/2025	3:45:00 PM	0.04
4/28/2025	4:00:00 PM	0.04
4/28/2025	4:15:00 PM	0.05
4/28/2025	4:30:00 PM	0.05
4/28/2025	4:45:00 PM	0.05
4/28/2025	5:00:00 PM	0.05
4/28/2025	5:15:00 PM	0.05
4/28/2025	5:30:00 PM	0.05
4/28/2025	5:45:00 PM	0.05
4/28/2025	6:00:00 PM	0.05
4/28/2025	6:15:00 PM	0.05
4/28/2025	6:30:00 PM	0.05
4/28/2025	6:45:00 PM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
4/28/2025	7:00:00 PM	0.05
4/28/2025	7:15:00 PM	0.05
4/28/2025	7:30:00 PM	0.05
4/28/2025	7:45:00 PM	0.05
4/28/2025	8:00:00 PM	0.05
4/28/2025	8:15:00 PM	0.06
4/28/2025	8:30:00 PM	0.06
4/28/2025	8:45:00 PM	0.06
4/28/2025	9:00:00 PM	0.06
4/28/2025	9:15:00 PM	0.06
4/28/2025	9:30:00 PM	0.06
4/28/2025	9:45:00 PM	0.06
4/28/2025	10:00:00 PM	0.06
4/28/2025	10:15:00 PM	0.06
4/28/2025	10:30:00 PM	0.06
4/28/2025	10:45:00 PM	0.06
4/28/2025	11:00:00 PM	0.06
4/28/2025	11:15:00 PM	0.06
4/28/2025	11:30:00 PM	0.06
4/28/2025	11:45:00 PM	0.05
4/29/2025	12:00:00 AM	0.06
4/29/2025	12:15:00 AM	0.06
4/29/2025	12:30:00 AM	0.06
4/29/2025	12:45:00 AM	0.06
4/29/2025	1:00:00 AM	0.06
4/29/2025	1:15:00 AM	0.06
4/29/2025	1:30:00 AM	0.06
4/29/2025	1:45:00 AM	0.05
4/29/2025	2:00:00 AM	0.06
4/29/2025	2:15:00 AM	0.05
4/29/2025	2:30:00 AM	0.05
4/29/2025	2:45:00 AM	0.05
4/29/2025	3:00:00 AM	0.05
4/29/2025	3:15:00 AM	0.05
4/29/2025	3:30:00 AM	0.06
4/29/2025	3:45:00 AM	0.06
4/29/2025	4:00:00 AM	0.06
4/29/2025	4:15:00 AM	0.06
4/29/2025	4:30:00 AM	0.06
4/29/2025	4:45:00 AM	0.06
4/29/2025	5:00:00 AM	0.06
4/29/2025	5:15:00 AM	0.06
4/29/2025	5:30:00 AM	0.06
4/29/2025	5:45:00 AM	0.06
4/29/2025	6:00:00 AM	0.06
4/29/2025	6:15:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
4/29/2025	6:30:00 AM	0.06
4/29/2025	6:45:00 AM	0.06
4/29/2025	7:00:00 AM	0.06
4/29/2025	7:15:00 AM	0.06
4/29/2025	7:30:00 AM	0.06
4/29/2025	7:45:00 AM	0.06
4/29/2025	8:00:00 AM	0.06
4/29/2025	8:15:00 AM	0.06
4/29/2025	8:30:00 AM	0.06
4/29/2025	8:45:00 AM	0.05
4/29/2025	9:00:00 AM	0.05
4/29/2025	9:15:00 AM	0.05
4/29/2025	9:30:00 AM	0.05
4/29/2025	9:45:00 AM	0.05
4/29/2025	10:00:00 AM	0.05
4/29/2025	10:15:00 AM	0.05
4/29/2025	10:30:00 AM	0.05
4/29/2025	10:45:00 AM	0.05
4/29/2025	11:00:00 AM	0.05
4/29/2025	11:15:00 AM	0.05
4/29/2025	11:30:00 AM	0.05
4/29/2025	11:45:00 AM	0.05
4/29/2025	12:00:00 PM	0.05
4/29/2025	12:15:00 PM	0.05
4/29/2025	12:30:00 PM	0.05
4/29/2025	12:45:00 PM	0.05
4/29/2025	1:00:00 PM	0.05
4/29/2025	1:15:00 PM	0.05
4/29/2025	1:30:00 PM	0.05
4/29/2025	1:45:00 PM	0.05
4/29/2025	2:00:00 PM	0.04
4/29/2025	2:15:00 PM	0.04
4/29/2025	2:30:00 PM	0.04
4/29/2025	2:45:00 PM	0.09
4/29/2025	3:00:00 PM	0.09
4/29/2025	3:15:00 PM	0.09
4/29/2025	3:30:00 PM	0.09
4/29/2025	3:45:00 PM	0.09
4/29/2025	4:00:00 PM	0.09
4/29/2025	4:15:00 PM	0.09
4/29/2025	4:30:00 PM	0.09
4/29/2025	4:45:00 PM	0.09
4/29/2025	5:00:00 PM	0.09
4/29/2025	5:15:00 PM	0.09
4/29/2025	5:30:00 PM	0.09
4/29/2025	5:45:00 PM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
4/29/2025	6:00:00 PM	0.09
4/29/2025	6:15:00 PM	0.09
4/29/2025	6:30:00 PM	0.09
4/29/2025	6:45:00 PM	0.09
4/29/2025	7:00:00 PM	0.09
4/29/2025	7:15:00 PM	0.09
4/29/2025	7:30:00 PM	0.09
4/29/2025	7:45:00 PM	0.09
4/29/2025	8:00:00 PM	0.09
4/29/2025	8:15:00 PM	0.09
4/29/2025	8:30:00 PM	0.09
4/29/2025	8:45:00 PM	0.09
4/29/2025	9:00:00 PM	0.09
4/29/2025	9:15:00 PM	0.09
4/29/2025	9:30:00 PM	0.09
4/29/2025	9:45:00 PM	0.08
4/29/2025	10:00:00 PM	0.08
4/29/2025	10:15:00 PM	0.08
4/29/2025	10:30:00 PM	0.08
4/29/2025	10:45:00 PM	0.08
4/29/2025	11:00:00 PM	0.08
4/29/2025	11:15:00 PM	0.08
4/29/2025	11:30:00 PM	0.08
4/29/2025	11:45:00 PM	0.08
4/30/2025	12:00:00 AM	0.07
4/30/2025	12:15:00 AM	0.07
4/30/2025	12:30:00 AM	0.07
4/30/2025	12:45:00 AM	0.07
4/30/2025	1:00:00 AM	0.07
4/30/2025	1:15:00 AM	0.07
4/30/2025	1:30:00 AM	0.07
4/30/2025	1:45:00 AM	0.07
4/30/2025	2:00:00 AM	0.07
4/30/2025	2:15:00 AM	0.06
4/30/2025	2:30:00 AM	0.06
4/30/2025	2:45:00 AM	0.06
4/30/2025	3:00:00 AM	0.06
4/30/2025	3:15:00 AM	0.06
4/30/2025	3:30:00 AM	0.06
4/30/2025	3:45:00 AM	0.06
4/30/2025	4:00:00 AM	0.06
4/30/2025	4:15:00 AM	0.06
4/30/2025	4:30:00 AM	0.06
4/30/2025	4:45:00 AM	0.06
4/30/2025	5:00:00 AM	0.06
4/30/2025	5:15:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
4/30/2025	5:30:00 AM	0.05
4/30/2025	5:45:00 AM	0.05
4/30/2025	6:00:00 AM	0.05
4/30/2025	6:15:00 AM	0.05
4/30/2025	6:30:00 AM	0.05
4/30/2025	6:45:00 AM	0.05
4/30/2025	7:00:00 AM	0.05
4/30/2025	7:15:00 AM	0.05
4/30/2025	7:30:00 AM	0.05
4/30/2025	7:45:00 AM	0.05
4/30/2025	8:00:00 AM	0.05
4/30/2025	8:15:00 AM	0.05
4/30/2025	8:30:00 AM	0.05
4/30/2025	8:45:00 AM	0.05
4/30/2025	9:00:00 AM	0.05
4/30/2025	9:15:00 AM	0.06
4/30/2025	9:30:00 AM	0.06
4/30/2025	9:45:00 AM	0.06
4/30/2025	10:00:00 AM	0.06
4/30/2025	10:15:00 AM	0.06
4/30/2025	10:30:00 AM	0.05
4/30/2025	10:45:00 AM	0.05
4/30/2025	11:00:00 AM	0.05
4/30/2025	11:15:00 AM	0.04
4/30/2025	11:30:00 AM	0.04
4/30/2025	11:45:00 AM	0.04
4/30/2025	12:00:00 PM	0.04
4/30/2025	12:15:00 PM	0.04
4/30/2025	12:30:00 PM	0.04
4/30/2025	12:45:00 PM	0.04
4/30/2025	1:00:00 PM	0.04
4/30/2025	1:15:00 PM	0.04
4/30/2025	1:30:00 PM	0.04
4/30/2025	1:45:00 PM	0.03
4/30/2025	2:00:00 PM	0.03
4/30/2025	2:15:00 PM	0.03
4/30/2025	2:30:00 PM	0.03
4/30/2025	2:45:00 PM	0.03
4/30/2025	3:00:00 PM	0.03
4/30/2025	3:15:00 PM	0.03
4/30/2025	3:30:00 PM	0.03
4/30/2025	3:45:00 PM	0.03
4/30/2025	4:00:00 PM	0.03
4/30/2025	4:15:00 PM	0.03
4/30/2025	4:30:00 PM	0.03
4/30/2025	4:45:00 PM	0.03

Georges Ditch Return Gage

DATE	TIME	GAGE
4/30/2025	5:00:00 PM	0.04
4/30/2025	5:15:00 PM	0.04
4/30/2025	5:30:00 PM	0.04
4/30/2025	5:45:00 PM	0.04
4/30/2025	6:00:00 PM	0.04
4/30/2025	6:15:00 PM	0.04
4/30/2025	6:30:00 PM	0.04
4/30/2025	6:45:00 PM	0.04
4/30/2025	7:00:00 PM	0.04
4/30/2025	7:15:00 PM	0.04
4/30/2025	7:30:00 PM	0.04
4/30/2025	7:45:00 PM	0.04
4/30/2025	8:00:00 PM	0.04
4/30/2025	8:15:00 PM	0.04
4/30/2025	8:30:00 PM	0.04
4/30/2025	8:45:00 PM	0.04
4/30/2025	9:00:00 PM	0.04
4/30/2025	9:15:00 PM	0.04
4/30/2025	9:30:00 PM	0.04
4/30/2025	9:45:00 PM	0.04
4/30/2025	10:00:00 PM	0.04
4/30/2025	10:15:00 PM	0.04
4/30/2025	10:30:00 PM	0.04
4/30/2025	10:45:00 PM	0.04
4/30/2025	11:00:00 PM	0.04
4/30/2025	11:15:00 PM	0.04
4/30/2025	11:30:00 PM	0.04
4/30/2025	11:45:00 PM	0.04

Party: BLP / BJA	Width: 21.2 ft	Processed by: BJA
Boat/Motor: BOAT	Area: 79.6 ft ²	Mean Velocity: 0.728 ft/s
Gage Height: 4.10 ft	G.H.Change: 0.000 ft	Discharge: 58.0 ft ³ /s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.00°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft ²	Diff.: 0.000%
Depth: Composite (BT)	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:		ADCP:	
BT 3-Beam Solution: YES	Max. Vel.: 1.32 ft/s	Type/Freq.: StreamPro / 2000 kHz	
WT 3-Beam Solution: YES	Max. Depth: 4.19 ft	Serial #: 2370	Firmware: 31.17
BT Error Vel.: 0.33 ft/s	Mean Depth: 3.76 ft	Bin Size: 17 cm	Blank: 3 cm
WT Error Vel.: 0.98 ft/s	% Meas.: 64.12	BT Mode: 10	BT Pings: 2
BT Up Vel.: 1.00 ft/s	Water Temp.: None	WT Mode: 12	WT Pings: 6
WT Up Vel.: 1.64 ft/s	ADCP Temp.: 70.6 °F		
Use Weighted Mean Depth: YES			

Performed Diag. Test: YES
 Performed Moving Bed Test: NO
 Performed Compass Calibration: NO Evaluation: NO
 Meas. Location: BRIDGE

Project Name: Station 01_0.mmt
 Software: 2.26.00.04

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	L	2	2	37	9.50	35.2	6.36	2.12	1.87	55.1	21	78	11:07	11:07	0.44	0.71	0	0
001	R	2	2	31	10.3	38.2	7.06	2.15	1.77	59.5	21	80	11:08	11:08	0.51	0.75	0	0
002	L	2	2	33	10.2	37.7	6.75	2.15	1.94	58.7	21	81	11:08	11:09	0.49	0.73	0	0
003	R	2	2	30	10.1	37.6	6.67	2.33	1.91	58.7	21	80	11:09	11:10	0.54	0.73	0	0
Mean		2	2	32	10.0	37.2	6.71	2.19	1.87	58.0	21	80	Total	00:03	0.50	0.73	0	0
SDev		0	0	3	0.361	1.34	0.290	0.096	0.076	1.98	0.3	1.0			0.04	0.02		
SD/M		0.0%	0.0%	10.0%	3.6%	3.6%	4.3%	4.4%	4.1%	3.4%	1.3%	1.3%			9.0%	2.4%		

Remarks:

Discharge for transects in *italics* have a total Q more than 5% from the mean

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	1	0	2	55	0.679	-0.105	3.491	0.016	0.013	0	45.6	38.7	63.6	141	123	0	35	33	35
2025	4	1	0	12	55	0.715	-0.125	3.491	0.02	0.016	0	46	38.7	52.9	141	123	0	34	33	34
2025	4	1	0	22	55	0.663	-0.089	3.491	0.016	0.013	0	45.2	38.7	72.2	140	123	0	35	33	34
2025	4	1	0	32	55	0.653	-0.069	3.491	0.013	0.01	0	46	38.7	70.5	141	124	0	34	34	34
2025	4	1	0	42	55	0.699	-0.082	3.491	0.01	0.007	0	45.6	38.3	73.1	141	123	0	35	34	34
2025	4	1	0	52	55	0.669	-0.069	3.491	0.01	0.007	0	45.2	38.3	73.1	140	123	0	35	34	34
2025	4	1	1	2	55	0.669	-0.095	3.491	0.013	0.01	0	45.2	37.8	71	140	122	0	35	34	34
2025	4	1	1	12	55	0.715	-0.098	3.488	0.013	0.01	0	45.2	38.7	49	140	123	0	35	33	34
2025	4	1	1	22	55	0.676	-0.085	3.488	0.01	0.007	0	45.2	38.7	51.6	140	123	0	35	33	34
2025	4	1	1	32	55	0.669	-0.112	3.488	0.013	0.01	0	45.2	37.8	50.3	140	122	0	35	34	35
2025	4	1	1	42	55	0.696	-0.043	3.488	0.01	0.007	0	45.6	38.3	54.6	140	122	0	34	33	35
2025	4	1	1	52	55	0.725	-0.089	3.491	0.01	0.007	0	45.2	38.3	73.5	140	122	0	35	33	34
2025	4	1	2	2	55	0.669	-0.112	3.491	0.01	0.007	0	45.2	38.3	74	140	122	0	35	33	34
2025	4	1	2	12	55	0.679	-0.128	3.491	0.016	0.013	0	46	38.3	74	141	123	0	34	34	34
2025	4	1	2	22	55	0.679	-0.092	3.491	0.013	0.01	0	45.6	38.3	73.5	140	122	0	34	33	34
2025	4	1	2	32	55	0.676	-0.085	3.491	0.01	0.007	0	45.2	37.8	68.8	140	122	0	35	34	34
2025	4	1	2	42	55	0.679	-0.102	3.491	0.016	0.013	0	45.6	37.8	70.1	140	122	0	34	34	34
2025	4	1	2	52	55	0.663	-0.115	3.491	0.013	0.01	0	45.6	37.8	74	140	122	0	34	34	34
2025	4	1	3	2	55	0.682	-0.092	3.491	0.016	0.013	0	45.6	38.3	74	140	122	0	34	33	34
2025	4	1	3	12	55	0.692	-0.112	3.491	0.013	0.01	0	45.2	37.8	74	140	122	0	35	34	35
2025	4	1	3	22	55	0.679	-0.082	3.491	0.013	0.01	0	45.2	38.3	75.3	140	122	0	35	33	34
2025	4	1	3	32	55	0.659	-0.079	3.491	0.01	0.007	0	45.2	37.8	74.4	140	122	0	35	34	34
2025	4	1	3	42	55	0.758	-0.098	3.491	0.016	0.013	0	44.7	37.8	74.8	139	122	0	35	34	34
2025	4	1	3	52	55	0.676	-0.105	3.491	0.013	0.01	0	45.2	37.8	75.3	140	122	0	35	34	34
2025	4	1	4	2	55	0.728	-0.095	3.491	0.01	0.007	0	45.2	38.3	75.3	140	122	0	35	33	34
2025	4	1	4	12	55	0.705	-0.131	3.491	0.016	0.013	0	45.2	38.3	75.3	140	123	0	35	34	34
2025	4	1	4	22	55	0.702	-0.102	3.491	0.013	0.01	0	44.7	38.3	75.3	139	122	0	35	33	34
2025	4	1	4	32	55	0.64	-0.098	3.491	0.013	0.01	0	45.2	38.3	74	140	123	0	35	34	35
2025	4	1	4	42	55	0.679	-0.105	3.491	0.016	0.013	0	44.7	37.8	75.3	139	121	0	35	33	34
2025	4	1	4	52	55	0.65	-0.092	3.491	0.013	0.01	0	45.2	38.3	75.3	140	122	0	35	33	34
2025	4	1	5	2	55	0.676	-0.115	3.491	0.013	0.01	0	44.7	37.4	75.7	139	121	0	35	34	34
2025	4	1	5	12	55	0.705	-0.105	3.491	0.01	0.007	0	44.7	37.4	75.7	139	121	0	35	34	34
2025	4	1	5	22	55	0.676	-0.089	3.491	0.013	0.01	0	44.7	37.8	73.5	139	122	0	35	34	34
2025	4	1	5	32	55	0.689	-0.102	3.491	0.01	0.007	0	44.7	37.8	74.8	139	122	0	35	34	34
2025	4	1	5	42	55	0.653	-0.069	3.491	0.013	0.01	0	43.9	37	73.1	137	120	0	35	34	34
2025	4	1	5	52	55	0.686	-0.118	3.491	0.016	0.013	0	44.3	37	73.5	138	120	0	35	34	34
2025	4	1	6	2	55	0.692	-0.115	3.488	0.013	0.01	0	44.7	37.4	56.8	139	121	0	35	34	34
2025	4	1	6	12	55	0.725	-0.108	3.488	0.01	0.007	0	44.3	37	68.8	138	119	0	35	33	34
2025	4	1	6	22	55	0.682	-0.072	3.488	0.016	0.013	0	43.9	37	58.9	137	119	0	35	33	34
2025	4	1	6	32	55	0.673	-0.089	3.488	0.01	0.007	0	44.3	37	65.8	138	119	0	35	33	34
2025	4	1	6	42	55	0.702	-0.089	3.488	0.01	0.007	0	43.9	36.5	73.5	137	119	0	35	34	34
2025	4	1	6	52	55	0.728	-0.079	3.488	0.013	0.01	0	43.4	36.5	61.9	136	119	0	35	34	34
2025	4	1	7	2	55	0.659	-0.072	3.488	0.016	0.013	0	43.4	37	57.2	136	119	0	35	33	35
2025	4	1	7	12	55	0.725	-0.102	3.488	0.013	0.01	0	43.9	37	56.8	137	119	0	35	33	35
2025	4	1	7	22	55	0.709	-0.098	3.488	0.01	0.007	0	43.9	36.5	57.6	137	119	0	35	34	34
2025	4	1	7	32	55	0.702	-0.079	3.488	0.013	0.01	0	43.4	36.1	54.2	136	118	0	35	34	35
2025	4	1	7	42	55	0.702	-0.082	3.488	0.016	0.013	0	43.4	36.1	52.5	136	118	0	35	34	35
2025	4	1	7	52	55	0.712	-0.095	3.488	0.01	0.007	0	43	36.5	55	135	118	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	1	8	2	55	0.673	-0.089	3.488	0.016	0.016	0	43.9	36.1	68.4	136	118	0	34	34	34
2025	4	1	8	12	55	0.653	-0.121	3.488	0.01	0.007	0	43	35.7	67.1	135	117	0	35	34	34
2025	4	1	8	22	55	0.702	-0.131	3.488	0.013	0.01	0	43.9	36.1	64.9	136	118	0	34	34	35
2025	4	1	8	32	55	0.686	-0.095	3.488	0.01	0.007	0	43.4	35.7	68.4	136	117	0	35	34	34
2025	4	1	8	42	55	0.705	-0.108	3.488	0.01	0.007	0	43	36.1	64.1	135	118	0	35	34	35
2025	4	1	8	52	55	0.699	-0.108	3.491	0.016	0.013	0	44.3	37.4	72.2	138	121	0	35	34	34
2025	4	1	9	2	55	0.715	-0.098	3.491	0.013	0.01	0	43.9	36.5	75.3	137	119	0	35	34	34
2025	4	1	9	12	55	0.666	-0.098	3.491	0.016	0.016	0	44.3	37	72.7	138	120	0	35	34	34
2025	4	1	9	22	55	0.689	-0.082	3.491	0.01	0.007	0	44.3	37.4	61.5	138	120	0	35	33	34
2025	4	1	9	32	55	0.692	-0.102	3.491	0.01	0.007	0	44.3	37	54.6	138	120	0	35	34	34
2025	4	1	9	42	55	0.715	-0.089	3.491	0.01	0.007	0	43.9	36.5	57.2	136	119	0	34	34	34
2025	4	1	9	52	55	0.63	-0.043	3.488	0.01	0.007	0	44.3	37.4	53.3	138	120	0	35	33	34
2025	4	1	10	2	55	0.636	-0.128	3.491	0.01	0.007	0	44.3	37	67.9	137	119	0	34	33	34
2025	4	1	10	12	55	0.679	-0.121	3.491	0.013	0.01	0	43.9	37	59.8	137	119	0	35	33	34
2025	4	1	10	22	55	0.689	-0.092	3.491	0.013	0.01	0	43.9	37.4	54.6	137	120	0	35	33	34
2025	4	1	10	32	55	0.676	-0.112	3.491	0.01	0.007	0	44.3	37	50.3	137	120	0	34	34	35
2025	4	1	10	42	55	0.712	-0.102	3.491	0.013	0.01	0	44.3	37.8	52.5	138	121	0	35	33	34
2025	4	1	10	52	55	0.673	-0.098	3.491	0.01	0.007	0	43.4	36.5	52.5	136	119	0	35	34	34
2025	4	1	11	2	55	0.656	-0.098	3.491	0.01	0.007	0	44.3	37	51.2	138	120	0	35	34	34
2025	4	1	11	12	55	0.679	-0.089	3.491	0.01	0.007	0	45.2	37.8	50.7	139	121	0	34	33	35
2025	4	1	11	22	55	0.663	-0.072	3.491	0.01	0.007	0	43.9	37.4	52	137	120	0	35	33	35
2025	4	1	11	32	55	0.699	-0.075	3.491	0.013	0.01	0	43.4	37	50.3	136	119	0	35	33	34
2025	4	1	11	42	55	0.699	-0.108	3.491	0.016	0.013	0	43.9	37.4	49.9	137	120	0	35	33	35
2025	4	1	11	52	55	0.686	-0.089	3.491	0.013	0.01	0	43.4	37	51.2	136	119	0	35	33	35
2025	4	1	12	2	55	0.696	-0.112	3.491	0.01	0.007	0	43.9	37	64.9	137	119	0	35	33	34
2025	4	1	12	12	55	0.696	-0.072	3.491	0.013	0.01	0	44.3	37	51.2	138	119	0	35	33	34
2025	4	1	12	22	55	0.725	-0.108	3.494	0.01	0.007	0	43.9	36.5	52.5	137	119	0	35	34	34
2025	4	1	12	32	55	0.659	-0.079	3.494	0.01	0.007	0	44.7	37.4	52	139	121	0	35	34	34
2025	4	1	12	42	55	0.709	-0.102	3.494	0.016	0.013	0	45.2	37.4	57.2	139	121	0	34	34	34
2025	4	1	12	52	55	0.692	-0.095	3.494	0.013	0.01	0	45.2	37.8	52.9	139	122	0	34	34	34
2025	4	1	13	2	55	0.696	-0.118	3.491	0.01	0.007	0	44.7	37.8	53.8	139	121	0	35	33	34
2025	4	1	13	12	55	0.699	-0.121	3.494	0.01	0.007	0	44.3	37	53.8	138	120	0	35	34	34
2025	4	1	13	22	55	0.669	-0.095	3.494	0.013	0.01	0	44.7	37.8	57.6	139	121	0	35	33	34
2025	4	1	13	32	55	0.679	-0.092	3.494	0.01	0.007	0	45.6	39.1	52	141	123	0	35	32	34
2025	4	1	13	42	55	0.696	-0.108	3.494	0.016	0.013	0	44.7	37.8	53.8	139	121	0	35	33	35
2025	4	1	13	52	55	0.699	-0.089	3.494	0.01	0.007	0	44.7	37.8	58.9	139	121	0	35	33	34
2025	4	1	14	2	55	0.659	-0.095	3.491	0.013	0.01	0	44.7	37.8	51.2	139	121	0	35	33	34
2025	4	1	14	12	55	0.689	-0.082	3.494	0.016	0.013	0	45.2	38.3	51.6	140	122	0	35	33	34
2025	4	1	14	22	55	0.715	-0.066	3.491	0.013	0.01	0	45.2	37.4	55	139	120	0	34	33	34
2025	4	1	14	32	55	0.689	-0.069	3.494	0.016	0.013	0	44.7	37.4	52.9	139	121	0	35	34	34
2025	4	1	14	42	55	0.696	-0.102	3.494	0.016	0.013	0	44.7	37.8	55.9	139	121	0	35	33	35
2025	4	1	14	52	55	0.686	-0.115	3.494	0.016	0.016	0	45.2	37.8	53.3	139	121	0	34	33	34
2025	4	1	15	2	55	0.705	-0.075	3.494	0.016	0.013	0	44.3	37	63.2	138	120	0	35	34	34
2025	4	1	15	12	55	0.696	-0.066	3.494	0.01	0.007	0	44.3	37.4	66.7	138	121	0	35	34	34
2025	4	1	15	22	55	0.699	-0.102	3.494	0.01	0.007	0	44.7	37.8	54.2	139	121	0	35	33	34
2025	4	1	15	32	55	0.669	-0.115	3.494	0.013	0.01	0	44.7	37	53.8	138	120	0	34	34	33
2025	4	1	15	42	55	0.643	-0.089	3.494	0.01	0.007	0	44.7	37.4	59.8	139	120	0	35	33	34
2025	4	1	15	52	55	0.702	-0.079	3.494	0.01	0.007	0	44.3	37.4	60.6	138	120	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	1	16	2	55	0.689	-0.098	3.491	0.013	0.01	0	43.4	35.7	61.5	135	116	0	34	33	34
2025	4	1	16	12	55	0.699	-0.089	3.494	0.013	0.01	0	42.6	34.8	65.8	134	115	0	35	34	34
2025	4	1	16	22	55	0.686	-0.089	3.494	0.01	0.007	0	43	35.3	70.1	135	116	0	35	34	34
2025	4	1	16	32	55	0.679	-0.092	3.494	0.01	0.007	0	43	35.3	73.1	135	116	0	35	34	34
2025	4	1	16	42	55	0.679	-0.131	3.494	0.01	0.007	0	42.1	34.4	72.2	133	114	0	35	34	34
2025	4	1	16	52	55	0.669	-0.102	3.494	0.013	0.01	0	42.1	34.8	74	133	114	0	35	33	34
2025	4	1	17	2	55	0.686	-0.095	3.494	0.013	0.01	0	43	35.3	73.5	134	115	0	34	33	34
2025	4	1	17	12	55	0.696	-0.089	3.494	0.013	0.01	0	43	34.4	58.9	134	114	0	34	34	34
2025	4	1	17	22	55	0.686	-0.075	3.494	0.01	0.007	0	42.6	35.3	73.1	134	115	0	35	33	34
2025	4	1	17	32	55	0.669	-0.085	3.494	0.013	0.01	0	42.6	34.8	74.4	134	115	0	35	34	34
2025	4	1	17	42	55	0.686	-0.089	3.494	0.013	0.01	0	43	35.7	74	134	116	0	34	33	34
2025	4	1	17	52	55	0.679	-0.098	3.494	0.013	0.01	0	43.4	35.7	74.4	135	116	0	34	33	33
2025	4	1	18	2	55	0.663	-0.075	3.494	0.013	0.01	0	42.6	35.3	73.5	134	115	0	35	33	35
2025	4	1	18	12	55	0.692	-0.079	3.494	0.013	0.01	0	43	35.3	74	134	115	0	34	33	34
2025	4	1	18	22	55	0.728	-0.092	3.491	0.01	0.007	0	43	35.7	73.1	134	116	0	34	33	34
2025	4	1	18	32	55	0.705	-0.089	3.494	0.01	0.007	0	43.4	35.7	74	135	116	0	34	33	34
2025	4	1	18	42	55	0.682	-0.059	3.494	0.013	0.01	0	43	35.3	74.4	134	115	0	34	33	34
2025	4	1	18	52	55	0.702	-0.085	3.494	0.013	0.01	0	42.6	35.7	74.4	134	116	0	35	33	34
2025	4	1	19	2	55	0.663	-0.082	3.491	0.01	0.007	0	43.9	36.1	74.4	136	117	0	34	33	34
2025	4	1	19	12	55	0.682	-0.089	3.494	0.01	0.007	0	44.3	36.5	72.2	137	118	0	34	33	34
2025	4	1	19	22	55	0.653	-0.098	3.494	0.013	0.01	0	43.9	36.5	74.4	137	118	0	35	33	34
2025	4	1	19	32	55	0.669	-0.069	3.494	0.01	0.007	0	43.9	36.1	74	137	118	0	35	34	34
2025	4	1	19	42	55	0.633	-0.046	3.491	0.013	0.01	0	44.3	36.5	73.5	137	119	0	34	34	34
2025	4	1	19	52	55	0.705	-0.098	3.494	0.016	0.013	0	43.9	36.1	74	137	118	0	35	34	34
2025	4	1	20	2	55	0.709	-0.112	3.494	0.013	0.01	0	44.3	36.5	74.8	137	118	0	34	33	34
2025	4	1	20	12	55	0.643	-0.135	3.494	0.016	0.013	0	43.4	36.5	74.8	136	118	0	35	33	34
2025	4	1	20	22	55	0.653	-0.089	3.494	0.016	0.013	0	45.2	37	74.4	139	120	0	34	34	34
2025	4	1	20	32	55	0.676	-0.102	3.491	0.013	0.01	0	44.3	37	75.3	138	119	0	35	33	34
2025	4	1	20	42	55	0.679	-0.098	3.494	0.013	0.01	0	44.3	37	75.3	138	119	0	35	33	35
2025	4	1	20	52	55	0.682	-0.072	3.491	0.01	0.007	0	44.3	37	74.8	138	119	0	35	33	34
2025	4	1	21	2	55	0.686	-0.072	3.491	0.013	0.01	0	44.7	37	75.7	138	119	0	34	33	34
2025	4	1	21	12	55	0.689	-0.098	3.491	0.01	0.007	0	44.7	37	75.3	138	119	0	34	33	34
2025	4	1	21	22	55	0.659	-0.118	3.491	0.013	0.01	0	44.3	37	75.3	138	119	0	35	33	34
2025	4	1	21	32	55	0.676	-0.102	3.491	0.013	0.01	0	44.7	37	74.8	139	120	0	35	34	34
2025	4	1	21	42	55	0.673	-0.125	3.491	0.013	0.01	0	44.7	36.5	75.7	139	119	0	35	34	33
2025	4	1	21	52	55	0.656	-0.092	3.491	0.01	0.007	0	44.3	36.5	74.8	138	119	0	35	34	35
2025	4	1	22	2	55	0.65	-0.105	3.491	0.013	0.01	0	44.3	36.5	75.3	138	118	0	35	33	34
2025	4	1	22	12	55	0.719	-0.108	3.491	0.016	0.013	0	43.9	35.7	75.7	137	117	0	35	34	34
2025	4	1	22	22	55	0.663	-0.095	3.491	0.013	0.01	0	43.9	36.1	76.1	137	118	0	35	34	34
2025	4	1	22	32	55	0.699	-0.089	3.491	0.013	0.01	0	44.3	36.1	75.7	137	118	0	34	34	34
2025	4	1	22	42	55	0.686	-0.085	3.491	0.013	0.01	0	44.7	36.5	68.8	138	119	0	34	34	34
2025	4	1	22	52	55	0.705	-0.089	3.491	0.013	0.01	0	44.3	36.5	74.8	138	119	0	35	34	35
2025	4	1	23	2	55	0.659	-0.098	3.488	0.016	0.013	0	44.3	36.1	75.3	138	118	0	35	34	35
2025	4	1	23	12	55	0.669	-0.085	3.488	0.016	0.013	0	44.3	36.1	75.3	138	118	0	35	34	34
2025	4	1	23	22	55	0.709	-0.102	3.488	0.016	0.013	0	43.9	36.1	59.8	137	118	0	35	34	35
2025	4	1	23	32	55	0.659	-0.092	3.488	0.016	0.013	0	43.9	36.5	52.9	137	118	0	35	33	35
2025	4	1	23	42	55	0.663	-0.102	3.488	0.01	0.007	0	43.9	36.1	53.3	137	118	0	35	34	34
2025	4	1	23	52	55	0.679	-0.112	3.488	0.016	0.016	0	43.9	36.5	62.4	137	118	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	2	0	2	55	0.692	-0.075	3.488	0.013	0.01	0	43.9	36.1	61.9	137	118	0	35	34	35
2025	4	2	0	12	55	0.692	-0.102	3.488	0.016	0.016	0	43.9	36.1	55	137	117	0	35	33	34
2025	4	2	0	22	55	0.679	-0.089	3.488	0.016	0.013	0	43.9	36.1	50.3	137	118	0	35	34	35
2025	4	2	0	32	55	0.653	-0.092	3.488	0.013	0.01	0	44.7	35.7	55.9	138	117	0	34	34	34
2025	4	2	0	42	55	0.735	-0.098	3.488	0.013	0.01	0	43.9	35.7	54.2	137	116	0	35	33	35
2025	4	2	0	52	55	0.755	-0.082	3.488	0.013	0.01	0	43.4	35.3	54.6	136	116	0	35	34	34
2025	4	2	1	2	55	0.63	-0.062	3.488	0.01	0.007	0	43.9	35.7	52.5	137	117	0	35	34	34
2025	4	2	1	12	55	0.722	-0.112	3.488	0.01	0.007	0	43.4	35.3	57.2	136	116	0	35	34	35
2025	4	2	1	22	55	0.699	-0.105	3.488	0.013	0.01	0	43.4	35.3	63.2	136	116	0	35	34	34
2025	4	2	1	32	55	0.676	-0.115	3.484	0.01	0.007	0	43.4	35.3	57.6	136	116	0	35	34	35
2025	4	2	1	42	55	0.715	-0.105	3.488	0.016	0.013	0	43.9	35.7	74.8	137	116	0	35	33	34
2025	4	2	1	52	55	0.676	-0.098	3.488	0.016	0.013	0	44.3	35.7	74.4	137	117	0	34	34	34
2025	4	2	2	2	55	0.679	-0.121	3.484	0.013	0.01	0	43.9	35.3	74.4	137	116	0	35	34	34
2025	4	2	2	12	55	0.728	-0.115	3.488	0.013	0.01	0	43.9	35.3	74.8	137	116	0	35	34	34
2025	4	2	2	22	55	0.689	-0.102	3.484	0.013	0.01	0	43.9	35.3	75.3	137	116	0	35	34	34
2025	4	2	2	32	55	0.656	-0.089	3.484	0.01	0.007	0	43.9	35.3	74.8	137	116	0	35	34	35
2025	4	2	2	42	55	0.725	-0.082	3.484	0.016	0.013	0	43.9	35.7	75.7	137	116	0	35	33	34
2025	4	2	2	52	55	0.696	-0.082	3.484	0.013	0.01	0	43.9	36.1	66.2	137	117	0	35	33	34
2025	4	2	3	2	55	0.679	-0.072	3.484	0.01	0.007	0	44.3	36.1	52.9	138	117	0	35	33	34
2025	4	2	3	12	55	0.64	-0.059	3.484	0.013	0.01	0	43.9	35.3	55.9	137	116	0	35	34	34
2025	4	2	3	22	55	0.696	-0.075	3.484	0.01	0.007	0	44.3	36.5	54.6	138	118	0	35	33	35
2025	4	2	3	32	55	0.689	-0.102	3.484	0.016	0.013	0	44.3	36.5	52.5	138	118	0	35	33	35
2025	4	2	3	42	55	0.669	-0.092	3.484	0.01	0.007	0	44.3	36.1	51.6	138	118	0	35	34	34
2025	4	2	3	52	55	0.696	-0.072	3.484	0.016	0.013	0	43.9	36.1	53.3	137	118	0	35	34	34
2025	4	2	4	2	55	0.65	-0.082	3.484	0.013	0.01	0	44.3	36.1	53.3	138	118	0	35	34	34
2025	4	2	4	12	55	0.682	-0.075	3.484	0.016	0.013	0	44.3	36.1	51.2	138	118	0	35	34	34
2025	4	2	4	22	55	0.636	-0.108	3.484	0.01	0.007	0	44.3	35.3	52	138	116	0	35	34	35
2025	4	2	4	32	55	0.666	-0.085	3.484	0.013	0.01	0	43.9	36.1	52.5	137	118	0	35	34	34
2025	4	2	4	42	55	0.673	-0.095	3.484	0.013	0.01	0	44.3	35.7	51.2	138	118	0	35	35	35
2025	4	2	4	52	55	0.682	-0.069	3.484	0.013	0.01	0	44.3	36.5	52	137	118	0	34	33	34
2025	4	2	5	2	55	0.709	-0.056	3.481	0.016	0.013	0	43.9	35.7	58.9	137	117	0	35	34	34
2025	4	2	5	12	55	0.686	-0.102	3.484	0.016	0.013	0	43.4	35.7	54.2	136	117	0	35	34	34
2025	4	2	5	22	55	0.659	-0.085	3.484	0.013	0.01	0	43.9	35.7	70.1	137	117	0	35	34	34
2025	4	2	5	32	55	0.65	-0.066	3.484	0.01	0.007	0	44.3	36.1	74.8	138	118	0	35	34	35
2025	4	2	5	42	55	0.679	-0.095	3.484	0.01	0.007	0	44.7	36.5	76.1	139	119	0	35	34	34
2025	4	2	5	52	55	0.679	-0.059	3.484	0.01	0.007	0	44.7	36.5	74.8	139	119	0	35	34	35
2025	4	2	6	2	55	0.669	-0.092	3.484	0.013	0.01	0	44.3	36.1	75.3	138	118	0	35	34	35
2025	4	2	6	12	55	0.63	-0.072	3.484	0.013	0.01	0	45.2	37	75.3	140	120	0	35	34	34
2025	4	2	6	22	55	0.709	-0.079	3.484	0.016	0.013	0	43.4	35.7	77.4	137	117	0	36	34	34
2025	4	2	6	32	55	0.735	-0.089	3.484	0.01	0.007	0	43	35.3	77	135	116	0	35	34	34
2025	4	2	6	42	55	0.65	-0.085	3.484	0.016	0.013	0	43.4	35.7	75.7	136	117	0	35	34	35
2025	4	2	6	52	55	0.663	-0.115	3.484	0.016	0.013	0	43.9	35.7	74	136	117	0	34	34	35
2025	4	2	7	2	55	0.679	-0.089	3.484	0.013	0.01	0	44.3	36.1	74	137	118	0	34	34	34
2025	4	2	7	12	55	0.646	-0.062	3.481	0.016	0.013	0	42.6	34.8	53.3	134	115	0	35	34	35
2025	4	2	7	22	55	0.699	-0.095	3.481	0.01	0.007	0	42.6	34.8	51.2	134	115	0	35	34	34
2025	4	2	7	32	55	0.673	-0.095	3.484	0.01	0.007	0	43.4	34.8	51.6	135	115	0	34	34	34
2025	4	2	7	42	55	0.682	-0.062	3.481	0.016	0.013	0	43	35.3	51.2	135	116	0	35	34	34
2025	4	2	7	52	55	0.712	-0.112	3.484	0.013	0.01	0	43	35.3	51.2	135	116	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	2	8	2	55	0.705	-0.079	3.481	0.01	0.007	0	43	34.8	50.7	135	115	0	35	34	34
2025	4	2	8	12	55	0.669	-0.125	3.481	0.01	0.007	0	43.4	35.7	50.7	136	116	0	35	33	34
2025	4	2	8	22	55	0.686	-0.085	3.481	0.016	0.013	0	43.4	35.3	50.7	136	116	0	35	34	34
2025	4	2	8	32	55	0.682	-0.072	3.484	0.016	0.013	0	43.9	35.7	47.7	137	117	0	35	34	35
2025	4	2	8	42	55	0.689	-0.095	3.481	0.013	0.01	0	45.2	37.4	50.3	140	120	0	35	33	34
2025	4	2	8	52	55	0.666	-0.115	3.481	0.016	0.016	0	44.7	36.5	50.7	139	119	0	35	34	35
2025	4	2	9	2	55	0.669	-0.079	3.484	0.01	0.007	0	44.7	37	48.6	139	120	0	35	34	34
2025	4	2	9	12	55	0.686	-0.098	3.484	0.013	0.01	0	43.9	36.1	51.6	137	117	0	35	33	34
2025	4	2	9	22	55	0.666	-0.108	3.481	0.016	0.016	0	44.7	37.4	50.3	139	120	0	35	33	34
2025	4	2	9	32	55	0.689	-0.079	3.481	0.01	0.007	0	45.2	37.8	49.9	140	121	0	35	33	34
2025	4	2	9	42	55	0.666	-0.082	3.484	0.013	0.01	0	44.3	37	52.9	138	119	0	35	33	35
2025	4	2	9	52	55	0.686	-0.095	3.484	0.016	0.013	0	43.9	36.1	50.3	137	118	0	35	34	35
2025	4	2	10	2	55	0.692	-0.098	3.484	0.01	0.007	0	43.9	36.1	52.5	137	118	0	35	34	35
2025	4	2	10	12	55	0.679	-0.089	3.481	0.013	0.01	0	44.3	37	51.6	138	119	0	35	33	34
2025	4	2	10	22	55	0.659	-0.089	3.484	0.01	0.007	0	44.3	37	53.8	138	119	0	35	33	35
2025	4	2	10	32	55	0.669	-0.105	3.484	0.013	0.01	0	45.6	37	55	140	120	0	34	34	33
2025	4	2	10	42	55	0.696	-0.105	3.481	0.013	0.01	0	45.6	37	49	140	120	0	34	34	35
2025	4	2	10	52	55	0.669	-0.105	3.484	0.013	0.01	0	44.3	35.7	52.5	137	117	0	34	34	34
2025	4	2	11	2	55	0.656	-0.049	3.484	0.013	0.01	0	44.7	37	51.2	139	120	0	35	34	35
2025	4	2	11	12	55	0.682	-0.092	3.481	0.013	0.01	0	44.7	37	53.3	139	119	0	35	33	35
2025	4	2	11	22	55	0.65	-0.079	3.484	0.01	0.007	0	44.7	37	64.5	139	119	0	35	33	34
2025	4	2	11	32	55	0.679	-0.125	3.484	0.01	0.007	0	45.2	37.4	55.5	140	121	0	35	34	34
2025	4	2	11	42	55	0.686	-0.095	3.484	0.013	0.01	0	45.2	37.4	62.4	140	120	0	35	33	35
2025	4	2	11	52	55	0.643	-0.085	3.484	0.013	0.01	0	45.6	37.8	62.4	141	121	0	35	33	34
2025	4	2	12	2	55	0.689	-0.118	3.484	0.013	0.01	0	44.7	37	63.6	139	120	0	35	34	34
2025	4	2	12	12	55	0.679	-0.069	3.484	0.013	0.01	0	44.3	36.5	51.2	138	118	0	35	33	34
2025	4	2	12	22	55	0.653	-0.089	3.484	0.013	0.01	0	44.7	36.5	56.8	139	119	0	35	34	35
2025	4	2	12	32	55	0.719	-0.095	3.484	0.013	0.01	0	44.3	36.1	53.3	138	118	0	35	34	34
2025	4	2	12	42	55	0.696	-0.089	3.484	0.013	0.01	0	44.7	36.1	71.4	138	118	0	34	34	34
2025	4	2	12	52	55	0.676	-0.105	3.481	0.013	0.01	0	43.4	35.7	52.9	136	116	0	35	33	34
2025	4	2	13	2	55	0.732	-0.108	3.484	0.013	0.01	0	44.3	36.1	52.9	137	117	0	34	33	34
2025	4	2	13	12	55	0.656	-0.089	3.484	0.01	0.007	0	43.9	36.1	52.9	137	118	0	35	34	34
2025	4	2	13	22	55	0.686	-0.079	3.481	0.016	0.013	0	44.3	36.1	52.9	137	118	0	34	34	35
2025	4	2	13	32	55	0.65	-0.089	3.484	0.013	0.01	0	43.4	35.7	52.9	136	116	0	35	33	35
2025	4	2	13	42	55	0.682	-0.072	3.481	0.013	0.01	0	43.9	35.7	48.6	136	116	0	34	33	35
2025	4	2	13	52	55	0.659	-0.089	3.484	0.02	0.016	0	44.3	36.5	49	138	118	0	35	33	34
2025	4	2	14	2	55	0.659	-0.079	3.484	0.013	0.01	0	44.3	36.5	49.9	138	118	0	35	33	35
2025	4	2	14	12	55	0.682	-0.095	3.481	0.016	0.013	0	43.9	35.7	50.3	137	117	0	35	34	34
2025	4	2	14	22	55	0.696	-0.066	3.481	0.01	0.007	0	44.7	37	49.9	139	119	0	35	33	34
2025	4	2	14	32	55	0.702	-0.069	3.481	0.013	0.01	0	45.2	37	52	139	119	0	34	33	34
2025	4	2	14	42	55	0.682	-0.105	3.478	0.013	0.01	0	45.2	36.1	49.9	139	118	0	34	34	34
2025	4	2	14	52	55	0.669	-0.095	3.478	0.013	0.01	0	43.9	35.7	54.6	137	116	0	35	33	34
2025	4	2	15	2	55	0.682	-0.079	3.478	0.016	0.013	0	44.7	36.5	52.9	139	118	0	35	33	34
2025	4	2	15	12	55	0.669	-0.052	3.474	0.013	0.01	0	43.4	34.8	58.9	136	115	0	35	34	34
2025	4	2	15	22	55	0.696	-0.069	3.474	0.016	0.013	0	43.9	34.8	55.5	136	115	0	34	34	34
2025	4	2	15	32	55	0.689	-0.118	3.474	0.01	0.007	0	43	34	56.8	134	112	0	34	33	34
2025	4	2	15	42	55	0.712	-0.105	3.474	0.01	0.007	0	43	33.5	59.3	134	112	0	34	34	34
2025	4	2	15	52	55	0.696	-0.072	3.478	0.013	0.01	0	43.9	34.8	70.5	136	114	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	2	16	2	55	0.705	-0.075	3.478	0.01	0.007	0	43.4	34.8	72.2	135	114	0	34	33	34
2025	4	2	16	12	55	0.653	-0.085	3.474	0.016	0.013	0	43.4	34.8	71.4	136	114	0	35	33	34
2025	4	2	16	22	55	0.673	-0.056	3.474	0.016	0.013	0	42.6	34	58	134	112	0	35	33	35
2025	4	2	16	32	55	0.719	-0.102	3.474	0.01	0.007	0	42.6	33.1	70.5	133	111	0	34	34	34
2025	4	2	16	42	55	0.696	-0.118	3.474	0.013	0.01	0	42.6	33.5	72.2	133	111	0	34	33	34
2025	4	2	16	52	55	0.709	-0.105	3.474	0.01	0.007	0	42.1	33.5	57.2	133	111	0	35	33	34
2025	4	2	17	2	55	0.699	-0.082	3.474	0.013	0.01	0	43	34.4	71.8	135	114	0	35	34	34
2025	4	2	17	12	55	0.696	-0.098	3.474	0.016	0.013	0	43.9	35.3	54.6	136	115	0	34	33	35
2025	4	2	17	22	55	0.682	-0.095	3.474	0.013	0.01	0	43.9	34.8	52.9	136	114	0	34	33	34
2025	4	2	17	32	55	0.659	-0.069	3.474	0.016	0.013	0	43	34	49.5	135	113	0	35	34	34
2025	4	2	17	42	55	0.696	-0.102	3.474	0.016	0.016	0	42.6	34	49.9	134	112	0	35	33	35
2025	4	2	17	52	55	0.682	-0.092	3.474	0.01	0.007	0	42.6	33.1	49.9	133	111	0	34	34	34
2025	4	2	18	2	55	0.686	-0.085	3.474	0.013	0.01	0	43.4	34	52.5	135	112	0	34	33	34
2025	4	2	18	12	55	0.686	-0.089	3.471	0.01	0.007	0	42.1	33.5	54.6	133	111	0	35	33	34
2025	4	2	18	22	55	0.669	-0.102	3.471	0.016	0.013	0	42.6	33.5	57.6	133	112	0	34	34	34
2025	4	2	18	32	55	0.692	-0.079	3.471	0.013	0.01	0	42.6	34	65.4	134	112	0	35	33	34
2025	4	2	18	42	55	0.702	-0.069	3.471	0.013	0.01	0	42.6	34	58.5	134	112	0	35	33	34
2025	4	2	18	52	55	0.673	-0.108	3.468	0.016	0.013	0	42.6	33.5	53.8	134	112	0	35	34	34
2025	4	2	19	2	55	0.705	-0.082	3.471	0.01	0.007	0	43.4	34.4	59.3	136	113	0	35	33	34
2025	4	2	19	12	55	0.636	-0.075	3.471	0.01	0.007	0	43.9	34.4	67.9	136	114	0	34	34	34
2025	4	2	19	22	55	0.696	-0.082	3.471	0.016	0.016	0	43.9	34.8	56.3	136	114	0	34	33	34
2025	4	2	19	32	55	0.636	-0.089	3.471	0.013	0.01	0	44.3	35.7	67.9	138	116	0	35	33	35
2025	4	2	19	42	55	0.676	-0.062	3.474	0.016	0.013	0	44.3	35.3	71.8	138	116	0	35	34	34
2025	4	2	19	52	55	0.673	-0.089	3.474	0.01	0.007	0	44.3	35.3	71.8	138	116	0	35	34	34
2025	4	2	20	2	55	0.689	-0.098	3.474	0.016	0.013	0	44.3	35.3	71.4	138	116	0	35	34	33
2025	4	2	20	12	55	0.705	-0.089	3.471	0.016	0.013	0	43.4	34.4	53.8	136	114	0	35	34	34
2025	4	2	20	22	55	0.692	-0.105	3.471	0.013	0.01	0	43.4	34.4	55	136	114	0	35	34	35
2025	4	2	20	32	55	0.732	-0.072	3.471	0.016	0.016	0	43.9	34.8	71.4	137	115	0	35	34	34
2025	4	2	20	42	55	0.656	-0.098	3.471	0.01	0.007	0	43.4	34.8	67.1	136	114	0	35	33	34
2025	4	2	20	52	55	0.722	-0.112	3.471	0.01	0.007	0	43.4	34.4	67.9	137	114	0	36	34	34
2025	4	2	21	2	55	0.673	-0.098	3.474	0.01	0.007	0	43.4	34.8	71.8	137	114	0	36	33	34
2025	4	2	21	12	55	0.653	-0.085	3.474	0.013	0.01	0	43.9	34.4	71	137	114	0	35	34	34
2025	4	2	21	22	55	0.686	-0.089	3.478	0.013	0.01	0	43.9	34.4	72.2	137	114	0	35	34	34
2025	4	2	21	32	55	0.653	-0.052	3.478	0.016	0.013	0	45.2	35.7	72.2	139	117	0	34	34	34
2025	4	2	21	42	55	0.673	-0.069	3.478	0.016	0.013	0	43.9	34.8	72.2	137	115	0	35	34	35
2025	4	2	21	52	55	0.673	-0.089	3.478	0.016	0.013	0	46	36.5	71.8	142	119	0	35	34	34
2025	4	2	22	2	55	0.686	-0.082	3.478	0.013	0.01	0	44.7	35.7	72.2	139	117	0	35	34	34
2025	4	2	22	12	55	0.673	-0.072	3.478	0.013	0.01	0	45.2	36.1	72.7	140	117	0	35	33	35
2025	4	2	22	22	55	0.682	-0.082	3.478	0.01	0.007	0	45.2	35.3	73.5	139	116	0	34	34	34
2025	4	2	22	32	55	0.64	-0.082	3.478	0.016	0.013	0	44.7	34.8	74	138	115	0	34	34	34
2025	4	2	22	42	55	0.679	-0.089	3.478	0.016	0.013	0	43.9	34.4	74	137	114	0	35	34	35
2025	4	2	22	52	55	0.653	-0.115	3.478	0.01	0.007	0	44.3	34.4	73.5	138	114	0	35	34	35
2025	4	2	23	2	55	0.679	-0.062	3.478	0.013	0.01	0	45.2	35.7	74	140	117	0	35	34	35
2025	4	2	23	12	55	0.673	-0.102	3.478	0.013	0.01	0	44.7	34.8	74	138	115	0	34	34	34
2025	4	2	23	22	55	0.699	-0.095	3.478	0.01	0.007	0	44.3	34.4	74.8	137	114	0	34	34	34
2025	4	2	23	32	55	0.692	-0.082	3.478	0.013	0.01	0	45.2	35.3	74.8	140	116	0	35	34	34
2025	4	2	23	42	55	0.653	-0.056	3.478	0.013	0.01	0	44.3	34.8	74.8	138	115	0	35	34	34
2025	4	2	23	52	55	0.692	-0.108	3.478	0.016	0.013	0	43.9	34.4	72.7	137	113	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	3	0	2	55	0.728	-0.082	3.478	0.013	0.01	0	44.7	35.3	74.4	139	115	0	35	33	35
2025	4	3	0	12	55	0.669	-0.098	3.478	0.013	0.01	0	43.9	34.4	75.7	137	113	0	35	33	34
2025	4	3	0	22	55	0.689	-0.089	3.478	0.013	0.01	0	43.9	34.4	75.7	137	113	0	35	33	34
2025	4	3	0	32	55	0.65	-0.102	3.478	0.013	0.01	0	43.9	33.5	75.3	136	112	0	34	34	35
2025	4	3	0	42	55	0.699	-0.062	3.478	0.01	0.007	0	43.9	34	75.3	137	112	0	35	33	34
2025	4	3	0	52	55	0.666	-0.075	3.478	0.01	0.007	0	43.9	34.4	74.4	137	113	0	35	33	35
2025	4	3	1	2	55	0.682	-0.069	3.474	0.013	0.01	0	43.4	34	75.3	136	112	0	35	33	34
2025	4	3	1	12	55	0.682	-0.072	3.478	0.013	0.01	0	43.4	34	74.8	136	113	0	35	34	34
2025	4	3	1	22	55	0.725	-0.105	3.478	0.013	0.01	0	43.9	34	75.3	136	113	0	34	34	34
2025	4	3	1	32	55	0.676	-0.043	3.478	0.016	0.013	0	43.4	34	75.7	136	112	0	35	33	34
2025	4	3	1	42	55	0.719	-0.075	3.478	0.016	0.013	0	43.4	34	75.7	136	113	0	35	34	35
2025	4	3	1	52	55	0.64	-0.046	3.474	0.013	0.01	0	43.9	34	75.3	136	113	0	34	34	35
2025	4	3	2	2	55	0.679	-0.115	3.478	0.016	0.013	0	43	33.5	75.7	135	112	0	35	34	35
2025	4	3	2	12	55	0.689	-0.098	3.474	0.01	0.007	0	43.4	33.5	75.7	136	112	0	35	34	35
2025	4	3	2	22	55	0.682	-0.105	3.478	0.013	0.01	0	44.3	34	75.7	137	113	0	34	34	35
2025	4	3	2	32	55	0.682	-0.089	3.474	0.013	0.01	0	43	33.5	75.3	135	112	0	35	34	34
2025	4	3	2	42	55	0.653	-0.082	3.478	0.01	0.007	0	44.3	34.4	75.7	138	114	0	35	34	34
2025	4	3	2	52	55	0.627	-0.092	3.474	0.016	0.016	0	43.9	33.5	76.1	136	112	0	34	34	35
2025	4	3	3	2	55	0.689	-0.079	3.474	0.01	0.007	0	43.4	34	76.1	136	113	0	35	34	35
2025	4	3	3	12	55	0.689	-0.092	3.474	0.013	0.01	0	43	33.5	76.1	135	111	0	35	33	35
2025	4	3	3	22	55	0.676	-0.131	3.474	0.01	0.007	0	43	33.1	76.1	135	111	0	35	34	35
2025	4	3	3	32	55	0.633	-0.085	3.474	0.016	0.016	0	43	33.1	76.5	135	111	0	35	34	35
2025	4	3	3	42	55	0.646	-0.049	3.474	0.016	0.013	0	43.4	33.5	75.7	136	112	0	35	34	35
2025	4	3	3	52	55	0.65	-0.095	3.474	0.016	0.013	0	43	33.5	76.5	135	111	0	35	33	35
2025	4	3	4	2	55	0.666	-0.052	3.474	0.013	0.01	0	43.4	33.5	76.5	136	112	0	35	34	35
2025	4	3	4	12	55	0.627	-0.075	3.474	0.016	0.013	0	43.9	33.5	76.5	137	112	0	35	34	35
2025	4	3	4	22	55	0.663	-0.075	3.478	0.01	0.007	0	43	33.1	76.5	135	111	0	35	34	35
2025	4	3	4	32	55	0.653	-0.115	3.474	0.013	0.01	0	43	33.5	76.5	135	111	0	35	33	35
2025	4	3	4	42	55	0.702	-0.085	3.474	0.013	0.01	0	43.9	33.5	76.1	136	112	0	34	34	34
2025	4	3	4	52	55	0.65	-0.085	3.478	0.016	0.013	0	43	32.7	77	135	110	0	35	34	35
2025	4	3	5	2	55	0.669	-0.075	3.474	0.01	0.007	0	43.4	33.1	76.5	136	111	0	35	34	35
2025	4	3	5	12	55	0.679	-0.102	3.474	0.013	0.01	0	43	33.1	76.1	136	111	0	36	34	35
2025	4	3	5	22	55	0.666	-0.052	3.474	0.016	0.013	0	43	32.7	76.5	135	110	0	35	34	35
2025	4	3	5	32	55	0.702	-0.098	3.474	0.01	0.007	0	43	32.7	76.5	135	109	0	35	33	35
2025	4	3	5	42	55	0.679	-0.072	3.474	0.013	0.01	0	43	32.3	77	135	109	0	35	34	34
2025	4	3	5	52	55	0.653	-0.075	3.474	0.01	0.007	0	43.4	32.7	76.1	137	110	0	36	34	35
2025	4	3	6	2	55	0.656	-0.115	3.474	0.01	0.007	0	43	31.8	75.7	135	109	0	35	35	35
2025	4	3	6	12	55	0.689	-0.085	3.474	0.016	0.016	0	43.9	33.1	76.5	137	111	0	35	34	34
2025	4	3	6	22	55	0.686	-0.102	3.474	0.013	0.01	0	43.9	32.7	76.5	137	111	0	35	35	35
2025	4	3	6	32	55	0.679	-0.098	3.478	0.01	0.007	0	43.9	34	76.5	137	113	0	35	34	35
2025	4	3	6	42	55	0.666	-0.072	3.478	0.013	0.01	0	43.4	32.7	77	135	110	0	34	34	34
2025	4	3	6	52	55	0.669	-0.085	3.478	0.013	0.01	0	43.9	33.5	77	137	112	0	35	34	34
2025	4	3	7	2	55	0.679	-0.118	3.478	0.013	0.01	0	43	33.1	77.4	135	111	0	35	34	34
2025	4	3	7	12	55	0.663	-0.092	3.478	0.016	0.013	0	43.4	33.1	77	136	112	0	35	35	35
2025	4	3	7	22	55	0.673	-0.098	3.478	0.01	0.007	0	42.6	32.3	77	134	109	0	35	34	35
2025	4	3	7	32	55	0.669	-0.098	3.478	0.01	0.007	0	42.6	32.7	75.7	134	110	0	35	34	34
2025	4	3	7	42	55	0.636	-0.085	3.478	0.013	0.01	0	43	33.1	74	135	111	0	35	34	35
2025	4	3	7	52	55	0.646	-0.043	3.478	0.013	0.01	0	43	32.7	75.3	135	110	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	3	8	2	55	0.663	-0.108	3.478	0.013	0.01	0	43.4	32.7	76.1	135	110	0	34	34	35
2025	4	3	8	12	55	0.656	-0.079	3.478	0.01	0.007	0	43.4	33.5	75.3	136	112	0	35	34	35
2025	4	3	8	22	55	0.699	-0.089	3.478	0.013	0.01	0	43.9	34	75.7	137	112	0	35	33	35
2025	4	3	8	32	55	0.673	-0.095	3.481	0.01	0.007	0	42.6	33.1	75.7	135	111	0	36	34	35
2025	4	3	8	42	55	0.679	-0.102	3.481	0.013	0.01	0	42.6	32.3	73.1	134	109	0	35	34	35
2025	4	3	8	52	55	0.663	-0.102	3.481	0.016	0.013	0	43	34	52.9	136	112	0	36	33	35
2025	4	3	9	2	55	0.643	-0.098	3.481	0.013	0.01	0	42.6	32.7	53.3	134	110	0	35	34	35
2025	4	3	9	12	55	0.679	-0.102	3.481	0.013	0.01	0	42.6	33.1	52	134	111	0	35	34	34
2025	4	3	9	22	55	0.673	-0.079	3.481	0.01	0.007	0	43	33.1	52.5	135	111	0	35	34	34
2025	4	3	9	32	55	0.663	-0.112	3.481	0.016	0.013	0	42.6	32.7	51.6	134	110	0	35	34	34
2025	4	3	9	42	55	0.64	-0.072	3.481	0.013	0.01	0	43.9	34	52	137	113	0	35	34	34
2025	4	3	9	52	55	0.686	-0.085	3.481	0.013	0.01	0	42.6	32.3	64.9	134	109	0	35	34	34
2025	4	3	10	2	55	0.653	-0.095	3.481	0.013	0.01	0	42.6	33.1	54.2	134	111	0	35	34	34
2025	4	3	10	12	55	0.666	-0.075	3.484	0.01	0.007	0	43	33.1	67.5	135	111	0	35	34	34
2025	4	3	10	22	55	0.653	-0.115	3.484	0.01	0.007	0	41.7	31.8	66.7	132	108	0	35	34	35
2025	4	3	10	32	55	0.696	-0.095	3.484	0.01	0.007	0	41.7	32.3	73.1	132	109	0	35	34	34
2025	4	3	10	42	55	0.686	-0.072	3.484	0.01	0.007	0	42.1	32.7	58.5	133	110	0	35	34	34
2025	4	3	10	52	55	0.679	-0.095	3.484	0.01	0.007	0	42.1	32.3	72.2	133	109	0	35	34	34
2025	4	3	11	2	55	0.679	-0.089	3.484	0.016	0.013	0	43.4	33.5	70.5	136	112	0	35	34	34
2025	4	3	11	12	55	0.682	-0.108	3.484	0.013	0.01	0	42.1	33.1	76.1	133	110	0	35	33	35
2025	4	3	11	22	55	0.679	-0.079	3.484	0.013	0.01	0	43	33.5	66.2	135	111	0	35	33	34
2025	4	3	11	32	55	0.669	-0.095	3.484	0.01	0.007	0	42.6	32.7	75.7	134	109	0	35	33	34
2025	4	3	11	42	55	0.656	-0.089	3.484	0.016	0.013	0	43	33.1	71.8	135	111	0	35	34	34
2025	4	3	11	52	55	0.696	-0.105	3.488	0.01	0.007	0	43.4	33.5	71.8	136	112	0	35	34	35
2025	4	3	12	2	55	0.646	-0.089	3.484	0.016	0.013	0	43.4	33.1	76.1	136	111	0	35	34	34
2025	4	3	12	12	55	0.669	-0.105	3.488	0.01	0.007	0	42.6	32.7	69.7	134	110	0	35	34	34
2025	4	3	12	22	55	0.686	-0.069	3.484	0.013	0.01	0	43	33.5	75.3	135	111	0	35	33	35
2025	4	3	12	32	55	0.663	-0.079	3.488	0.016	0.013	0	43	32.7	72.7	135	110	0	35	34	35
2025	4	3	12	42	55	0.686	-0.072	3.488	0.01	0.007	0	43	33.1	73.1	135	110	0	35	33	34
2025	4	3	12	52	55	0.673	-0.092	3.488	0.013	0.01	0	43	33.1	61.5	135	111	0	35	34	35
2025	4	3	13	2	55	0.699	-0.089	3.488	0.016	0.013	0	43	33.5	68.4	135	111	0	35	33	34
2025	4	3	13	12	55	0.682	-0.092	3.488	0.013	0.01	0	43.9	33.5	70.1	136	112	0	34	34	34
2025	4	3	13	22	55	0.689	-0.098	3.488	0.01	0.007	0	43	33.1	59.3	135	111	0	35	34	34
2025	4	3	13	32	55	0.676	-0.072	3.488	0.013	0.01	0	43	34	74.8	136	112	0	36	33	34
2025	4	3	13	42	55	0.65	-0.075	3.488	0.01	0.007	0	43	32.7	74.8	134	110	0	34	34	34
2025	4	3	13	52	55	0.659	-0.072	3.488	0.013	0.01	0	43	33.5	56.8	136	111	0	36	33	34
2025	4	3	14	2	55	0.682	-0.072	3.488	0.013	0.01	0	43	33.5	69.7	135	111	0	35	33	34
2025	4	3	14	12	55	0.712	-0.112	3.488	0.01	0.007	0	43	33.5	59.3	135	111	0	35	33	35
2025	4	3	14	22	55	0.722	-0.066	3.488	0.01	0.007	0	43.9	34	74.8	137	113	0	35	34	34
2025	4	3	14	32	55	0.692	-0.059	3.484	0.013	0.01	0	43.4	33.1	53.3	135	111	0	34	34	34
2025	4	3	14	42	55	0.669	-0.062	3.488	0.016	0.013	0	43	32.7	70.1	135	110	0	35	34	34
2025	4	3	14	52	55	0.676	-0.095	3.488	0.013	0.01	0	43	33.1	72.2	134	110	0	34	33	34
2025	4	3	15	2	55	0.712	-0.079	3.484	0.01	0.007	0	43	33.1	64.9	135	111	0	35	34	34
2025	4	3	15	12	55	0.653	-0.059	3.484	0.016	0.013	0	42.6	33.1	65.8	134	110	0	35	33	34
2025	4	3	15	22	55	0.696	-0.102	3.484	0.01	0.007	0	41.3	31.4	67.1	131	106	0	35	33	35
2025	4	3	15	32	55	0.636	-0.095	3.488	0.013	0.01	0	43.4	33.5	72.2	135	111	0	34	33	35
2025	4	3	15	42	55	0.692	-0.115	3.484	0.013	0.01	0	42.6	32.3	69.7	133	109	0	34	34	35
2025	4	3	15	52	55	0.65	-0.082	3.488	0.013	0.01	0	42.6	32.3	74	134	109	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	3	16	2	55	0.692	-0.089	3.484	0.01	0.007	0	42.6	32.7	73.1	134	109	0	35	33	34
2025	4	3	16	12	55	0.715	-0.098	3.484	0.016	0.013	0	43	32.7	73.5	134	109	0	34	33	34
2025	4	3	16	22	55	0.686	-0.085	3.484	0.016	0.013	0	42.6	32.7	61.9	134	109	0	35	33	34
2025	4	3	16	32	55	0.696	-0.075	3.484	0.01	0.007	0	42.6	31.8	72.2	133	107	0	34	33	34
2025	4	3	16	42	55	0.696	-0.072	3.484	0.01	0.007	0	42.1	31.8	70.5	133	107	0	35	33	34
2025	4	3	16	52	55	0.705	-0.098	3.481	0.013	0.01	0	42.6	32.3	70.1	133	108	0	34	33	35
2025	4	3	17	2	55	0.689	-0.108	3.481	0.013	0.01	0	42.1	31.4	60.6	133	107	0	35	34	34
2025	4	3	17	12	55	0.666	-0.108	3.484	0.016	0.013	0	43	31.4	72.7	134	107	0	34	34	34
2025	4	3	17	22	55	0.663	-0.049	3.484	0.016	0.013	0	43	31.4	73.1	134	107	0	34	34	34
2025	4	3	17	32	55	0.709	-0.069	3.484	0.01	0.007	0	42.1	31.4	74	133	106	0	35	33	34
2025	4	3	17	42	55	0.699	-0.092	3.484	0.01	0.007	0	42.6	31.4	73.5	134	106	0	35	33	34
2025	4	3	17	52	55	0.679	-0.072	3.484	0.013	0.01	0	43	31.8	74	135	108	0	35	34	33
2025	4	3	18	2	55	0.663	-0.105	3.484	0.01	0.007	0	43.9	33.5	73.1	137	111	0	35	33	34
2025	4	3	18	12	55	0.669	-0.095	3.481	0.01	0.007	0	43.4	32.3	72.7	136	109	0	35	34	34
2025	4	3	18	22	55	0.696	-0.095	3.481	0.013	0.01	0	43	32.7	71.8	135	109	0	35	33	34
2025	4	3	18	32	55	0.673	-0.072	3.481	0.01	0.007	0	43.4	32.7	73.1	135	109	0	34	33	34
2025	4	3	18	42	55	0.692	-0.118	3.484	0.01	0.007	0	43.4	32.3	73.5	136	109	0	35	34	34
2025	4	3	18	52	55	0.719	-0.085	3.481	0.016	0.013	0	43	32.3	72.7	135	108	0	35	33	35
2025	4	3	19	2	55	0.673	-0.072	3.481	0.016	0.013	0	43.9	33.1	73.1	136	110	0	34	33	34
2025	4	3	19	12	55	0.659	-0.121	3.478	0.013	0.01	0	43.9	32.7	55.5	136	109	0	34	33	34
2025	4	3	19	22	55	0.663	-0.059	3.481	0.013	0.01	0	44.3	33.1	58.5	137	110	0	34	33	34
2025	4	3	19	32	55	0.682	-0.072	3.481	0.01	0.007	0	43.9	33.1	69.2	137	110	0	35	33	35
2025	4	3	19	42	55	0.692	-0.085	3.481	0.013	0.01	0	43.9	33.1	67.9	137	110	0	35	33	34
2025	4	3	19	52	55	0.676	-0.072	3.484	0.013	0.01	0	43.9	33.1	73.5	137	110	0	35	33	34
2025	4	3	20	2	55	0.682	-0.082	3.481	0.01	0.007	0	44.3	33.1	73.1	138	111	0	35	34	34
2025	4	3	20	12	55	0.653	-0.075	3.481	0.013	0.01	0	43.4	33.1	73.1	136	110	0	35	33	35
2025	4	3	20	22	55	0.676	-0.102	3.481	0.013	0.01	0	43.9	33.1	71.8	137	110	0	35	33	34
2025	4	3	20	32	55	0.673	-0.102	3.481	0.013	0.01	0	43.9	32.7	73.1	137	110	0	35	34	34
2025	4	3	20	42	55	0.689	-0.075	3.481	0.013	0.01	0	43.9	32.7	72.7	137	110	0	35	34	35
2025	4	3	20	52	55	0.676	-0.098	3.481	0.013	0.01	0	43.9	32.7	73.1	137	110	0	35	34	34
2025	4	3	21	2	55	0.712	-0.085	3.481	0.016	0.016	0	43.9	32.7	72.7	137	110	0	35	34	35
2025	4	3	21	12	55	0.702	-0.102	3.481	0.01	0.007	0	43.9	32.3	74	137	109	0	35	34	34
2025	4	3	21	22	55	0.689	-0.089	3.481	0.01	0.007	0	43.9	33.1	74	137	110	0	35	33	34
2025	4	3	21	32	55	0.676	-0.092	3.481	0.016	0.013	0	44.3	33.1	74.4	137	110	0	34	33	35
2025	4	3	21	42	55	0.669	-0.102	3.481	0.01	0.007	0	44.3	33.1	75.7	138	110	0	35	33	35
2025	4	3	21	52	55	0.676	-0.125	3.481	0.016	0.013	0	43.9	32.7	76.1	136	109	0	34	33	35
2025	4	3	22	2	55	0.696	-0.069	3.481	0.01	0.007	0	43.9	33.1	75.7	137	110	0	35	33	35
2025	4	3	22	12	55	0.696	-0.105	3.481	0.013	0.01	0	44.3	33.1	74.8	138	111	0	35	34	34
2025	4	3	22	22	55	0.663	-0.102	3.481	0.016	0.013	0	44.3	32.7	75.3	137	110	0	34	34	34
2025	4	3	22	32	55	0.663	-0.115	3.481	0.016	0.013	0	44.3	32.7	74.8	138	110	0	35	34	35
2025	4	3	22	42	55	0.636	-0.089	3.481	0.01	0.007	0	44.3	32.7	75.7	138	110	0	35	34	35
2025	4	3	22	52	55	0.722	-0.128	3.481	0.016	0.016	0	44.3	33.1	75.3	138	110	0	35	33	34
2025	4	3	23	2	55	0.673	-0.089	3.481	0.016	0.013	0	44.3	32.7	75.3	138	110	0	35	34	34
2025	4	3	23	12	55	0.682	-0.079	3.481	0.01	0.007	0	45.2	33.1	73.5	139	110	0	34	33	35
2025	4	3	23	22	55	0.653	-0.059	3.481	0.01	0.007	0	44.3	33.1	75.3	138	110	0	35	33	35
2025	4	3	23	32	55	0.636	-0.085	3.478	0.013	0.01	0	44.7	33.1	75.7	138	110	0	34	33	35
2025	4	3	23	42	55	0.663	-0.092	3.481	0.01	0.007	0	44.3	33.1	77	138	110	0	35	33	34
2025	4	3	23	52	55	0.653	-0.098	3.478	0.01	0.007	0	43.4	32.3	76.5	137	109	0	36	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	4	0	2	55	0.666	-0.069	3.478	0.01	0.007	0	43.9	32.3	62.4	137	109	0	35	34	35
2025	4	4	0	12	55	0.692	-0.075	3.478	0.01	0.007	0	43.9	32.3	54.2	137	109	0	35	34	34
2025	4	4	0	22	55	0.679	-0.059	3.478	0.013	0.01	0	44.3	33.1	50.7	138	110	0	35	33	34
2025	4	4	0	32	55	0.679	-0.102	3.478	0.016	0.013	0	43.9	31.8	70.5	137	108	0	35	34	35
2025	4	4	0	42	55	0.663	-0.075	3.478	0.01	0.007	0	43.4	31.4	76.5	136	107	0	35	34	34
2025	4	4	0	52	55	0.676	-0.128	3.478	0.01	0.007	0	43.4	31.4	75.3	136	107	0	35	34	35
2025	4	4	1	2	55	0.673	-0.079	3.478	0.01	0.007	0	43.9	31.4	76.1	136	107	0	34	34	34
2025	4	4	1	12	55	0.712	-0.118	3.478	0.013	0.01	0	43.9	31.8	74	137	108	0	35	34	35
2025	4	4	1	22	55	0.692	-0.085	3.478	0.013	0.01	0	43.4	31.8	75.3	137	108	0	36	34	35
2025	4	4	1	32	55	0.659	-0.115	3.474	0.016	0.016	0	43.4	32.3	67.9	136	108	0	35	33	34
2025	4	4	1	42	55	0.65	-0.072	3.478	0.013	0.01	0	43	31.4	73.5	136	107	0	36	34	35
2025	4	4	1	52	55	0.676	-0.072	3.474	0.01	0.007	0	43	31.8	69.2	135	108	0	35	34	35
2025	4	4	2	2	55	0.682	-0.085	3.474	0.013	0.01	0	43.4	32.3	56.8	137	109	0	36	34	34
2025	4	4	2	12	55	0.64	-0.079	3.474	0.013	0.01	0	43.4	31.8	60.2	136	108	0	35	34	34
2025	4	4	2	22	55	0.659	-0.056	3.474	0.01	0.007	0	43.4	31.8	55.9	136	108	0	35	34	34
2025	4	4	2	32	55	0.646	-0.079	3.474	0.01	0.007	0	43	31.4	58.9	135	107	0	35	34	35
2025	4	4	2	42	55	0.692	-0.056	3.474	0.016	0.013	0	43.4	31.8	69.7	136	108	0	35	34	35
2025	4	4	2	52	55	0.63	-0.072	3.474	0.013	0.01	0	43.4	32.3	75.3	136	109	0	35	34	35
2025	4	4	3	2	55	0.659	-0.072	3.474	0.01	0.007	0	43	31.8	76.5	135	108	0	35	34	34
2025	4	4	3	12	55	0.666	-0.131	3.474	0.013	0.01	0	42.6	31.8	75.7	135	108	0	36	34	35
2025	4	4	3	22	55	0.643	-0.066	3.474	0.01	0.007	0	43.4	32.3	75.3	136	109	0	35	34	35
2025	4	4	3	32	55	0.646	-0.049	3.474	0.013	0.01	0	43.4	32.7	75.3	136	109	0	35	33	34
2025	4	4	3	42	55	0.64	-0.01	3.474	0.013	0.01	0	43	32.3	75.3	136	109	0	36	34	35
2025	4	4	3	52	55	0.656	-0.089	3.474	0.01	0.007	0	43	32.3	74	136	109	0	36	34	35
2025	4	4	4	2	55	0.705	-0.072	3.474	0.016	0.016	0	43	31.8	74	135	108	0	35	34	35
2025	4	4	4	12	55	0.673	-0.069	3.474	0.013	0.01	0	43	32.3	74	135	109	0	35	34	34
2025	4	4	4	22	55	0.689	-0.059	3.474	0.013	0.01	0	43.4	32.3	72.7	136	109	0	35	34	35
2025	4	4	4	32	55	0.627	-0.092	3.474	0.013	0.01	0	43.4	32.3	74.8	136	109	0	35	34	35
2025	4	4	4	42	55	0.702	-0.112	3.474	0.013	0.01	0	42.6	31.8	73.1	135	108	0	36	34	34
2025	4	4	4	52	55	0.679	-0.082	3.474	0.016	0.013	0	43.9	33.1	74	137	110	0	35	33	35
2025	4	4	5	2	55	0.702	-0.112	3.474	0.01	0.007	0	43.4	32.3	76.1	136	109	0	35	34	34
2025	4	4	5	12	55	0.666	-0.095	3.474	0.013	0.01	0	44.3	34.4	73.5	139	114	0	36	34	35
2025	4	4	5	22	55	0.653	-0.102	3.474	0.013	0.01	0	45.2	33.5	75.3	140	112	0	35	34	34
2025	4	4	5	32	55	0.669	-0.125	3.474	0.01	0.007	0	44.3	33.1	75.7	138	111	0	35	34	34
2025	4	4	5	42	55	0.719	-0.092	3.474	0.013	0.01	0	44.3	33.1	75.7	138	111	0	35	34	34
2025	4	4	5	52	55	0.679	-0.059	3.474	0.016	0.013	0	43.9	32.7	75.3	137	110	0	35	34	34
2025	4	4	6	2	55	0.692	-0.105	3.474	0.01	0.007	0	44.3	33.5	74.8	138	111	0	35	33	35
2025	4	4	6	12	55	0.686	-0.085	3.474	0.013	0.01	0	44.7	33.5	75.3	139	112	0	35	34	34
2025	4	4	6	22	55	0.65	-0.085	3.474	0.013	0.01	0	44.7	33.1	74.8	139	111	0	35	34	35
2025	4	4	6	32	55	0.669	-0.098	3.474	0.013	0.01	0	44.3	33.1	75.3	138	111	0	35	34	35
2025	4	4	6	42	55	0.669	-0.059	3.474	0.013	0.01	0	43.9	32.7	75.7	137	110	0	35	34	35
2025	4	4	6	52	55	0.646	-0.102	3.474	0.013	0.01	0	43.9	32.7	75.3	137	110	0	35	34	35
2025	4	4	7	2	55	0.643	-0.098	3.474	0.01	0.007	0	43	32.7	76.1	135	109	0	35	33	34
2025	4	4	7	12	55	0.676	-0.102	3.474	0.013	0.01	0	44.3	33.1	52.9	138	111	0	35	34	35
2025	4	4	7	22	55	0.659	-0.095	3.471	0.013	0.01	0	42.1	31.4	55.5	133	107	0	35	34	35
2025	4	4	7	32	55	0.663	-0.072	3.468	0.013	0.01	0	43.4	32.7	50.7	136	110	0	35	34	35
2025	4	4	7	42	55	0.653	-0.072	3.471	0.016	0.013	0	43	32.3	52	135	109	0	35	34	35
2025	4	4	7	52	55	0.656	-0.105	3.471	0.01	0.007	0	42.1	32.3	53.8	134	109	0	36	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	4	8	2	55	0.633	-0.059	3.471	0.013	0.01	0	42.6	31.8	51.6	134	108	0	35	34	35
2025	4	4	8	12	55	0.692	-0.075	3.471	0.01	0.007	0	42.6	32.3	52.5	134	108	0	35	33	35
2025	4	4	8	22	55	0.659	-0.075	3.471	0.013	0.01	0	43.9	33.1	51.2	137	111	0	35	34	35
2025	4	4	8	32	55	0.696	-0.092	3.471	0.013	0.01	0	43	33.1	50.3	135	111	0	35	34	34
2025	4	4	8	42	55	0.689	-0.085	3.471	0.013	0.01	0	44.7	34.4	49.9	138	114	0	34	34	34
2025	4	4	8	52	55	0.656	-0.079	3.471	0.013	0.01	0	43	32.7	49.5	135	111	0	35	35	35
2025	4	4	9	2	55	0.676	-0.092	3.471	0.01	0.007	0	43.4	33.5	51.6	135	112	0	34	34	34
2025	4	4	9	12	55	0.682	-0.085	3.471	0.01	0.007	0	43.4	34.4	49.5	136	113	0	35	33	35
2025	4	4	9	22	55	0.666	-0.098	3.471	0.01	0.007	0	43.4	34	49	136	113	0	35	34	35
2025	4	4	9	32	55	0.663	-0.095	3.468	0.013	0.01	0	43.4	32.7	50.3	136	110	0	35	34	35
2025	4	4	9	42	55	0.669	-0.095	3.468	0.01	0.007	0	43.9	31.8	49	137	108	0	35	34	35
2025	4	4	9	52	55	0.679	-0.085	3.468	0.01	0.007	0	43.4	31.4	49.9	136	107	0	35	34	35
2025	4	4	10	2	55	0.673	-0.128	3.468	0.013	0.01	0	44.3	32.7	49.5	137	110	0	34	34	34
2025	4	4	10	12	55	0.686	-0.075	3.468	0.016	0.013	0	43.9	34	50.7	137	112	0	35	33	35
2025	4	4	10	22	55	0.656	-0.102	3.471	0.01	0.007	0	44.3	34	50.3	137	113	0	34	34	34
2025	4	4	10	32	55	0.659	-0.049	3.471	0.016	0.013	0	43.9	34	50.7	136	113	0	34	34	34
2025	4	4	10	42	55	0.696	-0.131	3.474	0.01	0.007	0	43.4	34.8	56.8	136	114	0	35	33	34
2025	4	4	10	52	55	0.669	-0.056	3.478	0.01	0.007	0	43.4	34.8	68.4	136	114	0	35	33	34
2025	4	4	11	2	55	0.686	-0.115	3.478	0.01	0.007	0	43.4	34	61.5	136	113	0	35	34	35
2025	4	4	11	12	55	0.702	-0.089	3.481	0.013	0.01	0	43.4	34.8	77.4	137	115	0	36	34	34
2025	4	4	11	22	55	0.656	-0.089	3.478	0.013	0.01	0	43.4	34	74.4	136	113	0	35	34	35
2025	4	4	11	32	55	0.64	-0.026	3.478	0.013	0.01	0	43.4	35.3	76.1	136	115	0	35	33	35
2025	4	4	11	42	55	0.679	-0.072	3.468	0.013	0.01	0	43.9	34.8	71.8	137	114	0	35	33	34
2025	4	4	11	52	55	0.689	-0.089	3.468	0.01	0.007	0	43.9	34.4	66.7	137	114	0	35	34	34
2025	4	4	12	2	55	0.699	-0.066	3.468	0.013	0.01	0	43	34	72.2	135	112	0	35	33	35
2025	4	4	12	12	55	0.725	-0.115	3.465	0.013	0.01	0	42.6	33.5	66.2	134	111	0	35	33	34
2025	4	4	12	22	55	0.702	-0.115	3.468	0.013	0.01	0	43.4	34.4	72.2	136	113	0	35	33	35
2025	4	4	12	32	55	0.653	-0.059	3.465	0.01	0.007	0	43	33.5	61.9	135	112	0	35	34	35
2025	4	4	12	42	55	0.686	-0.095	3.465	0.016	0.013	0	43.4	34.4	54.2	136	113	0	35	33	34
2025	4	4	12	52	55	0.663	-0.095	3.465	0.013	0.01	0	43.4	34.4	56.8	136	113	0	35	33	34
2025	4	4	13	2	55	0.712	-0.072	3.465	0.013	0.01	0	43	33.5	56.8	135	112	0	35	34	34
2025	4	4	13	12	55	0.696	-0.085	3.465	0.01	0.007	0	43.4	34	71	136	113	0	35	34	34
2025	4	4	13	22	55	0.705	-0.095	3.465	0.01	0.007	0	43.9	34.8	73.5	137	114	0	35	33	34
2025	4	4	13	32	55	0.646	-0.089	3.465	0.013	0.01	0	43	33.5	73.5	135	112	0	35	34	34
2025	4	4	13	42	55	0.679	-0.062	3.465	0.016	0.016	0	43.9	34	66.7	136	113	0	34	34	34
2025	4	4	13	52	55	0.676	-0.112	3.465	0.013	0.01	0	43.9	34.8	63.2	137	114	0	35	33	35
2025	4	4	14	2	55	0.663	-0.072	3.465	0.013	0.01	0	43.4	34.8	66.7	136	114	0	35	33	34
2025	4	4	14	12	55	0.614	-0.072	3.465	0.01	0.007	0	42.6	34	73.5	134	112	0	35	33	34
2025	4	4	14	22	55	0.689	-0.072	3.465	0.01	0.007	0	42.6	33.1	62.8	133	111	0	34	34	35
2025	4	4	14	32	55	0.653	-0.089	3.465	0.01	0.007	0	42.1	33.1	73.5	133	111	0	35	34	34
2025	4	4	14	42	55	0.673	-0.043	3.465	0.013	0.01	0	42.1	33.1	74.8	133	111	0	35	34	34
2025	4	4	14	52	55	0.696	-0.089	3.465	0.013	0.01	0	42.6	32.3	59.8	133	109	0	34	34	34
2025	4	4	15	2	55	0.692	-0.072	3.465	0.013	0.01	0	42.6	33.1	68.8	134	111	0	35	34	34
2025	4	4	15	12	55	0.666	-0.089	3.465	0.013	0.01	0	42.1	33.5	73.5	133	111	0	35	33	35
2025	4	4	15	22	55	0.646	-0.118	3.465	0.016	0.013	0	42.6	33.5	74.4	133	112	0	34	34	34
2025	4	4	15	32	55	0.633	-0.062	3.468	0.016	0.013	0	42.1	33.1	73.1	133	111	0	35	34	34
2025	4	4	15	42	55	0.676	-0.095	3.465	0.01	0.007	0	42.6	33.5	72.2	134	112	0	35	34	34
2025	4	4	15	52	55	0.653	-0.085	3.465	0.016	0.013	0	41.3	31.8	64.9	131	108	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	4	16	2	55	0.643	-0.046	3.465	0.013	0.01	0	41.3	32.3	74.4	131	108	0	35	33	34
2025	4	4	16	12	55	0.643	-0.052	3.468	0.01	0.007	0	42.6	32.7	74	134	109	0	35	33	34
2025	4	4	16	22	55	0.679	-0.075	3.465	0.016	0.016	0	42.6	31.8	52.5	133	108	0	34	34	34
2025	4	4	16	32	55	0.659	-0.069	3.465	0.016	0.013	0	42.1	32.3	61.9	133	109	0	35	34	34
2025	4	4	16	42	55	0.682	-0.089	3.465	0.013	0.01	0	42.1	32.7	69.2	133	109	0	35	33	34
2025	4	4	16	52	55	0.614	-0.072	3.468	0.01	0.007	0	42.1	32.3	74	133	109	0	35	34	34
2025	4	4	17	2	55	0.682	-0.082	3.468	0.016	0.013	0	42.1	32.3	71.8	133	108	0	35	33	34
2025	4	4	17	12	55	0.696	-0.082	3.468	0.016	0.013	0	42.1	31.8	74.8	132	107	0	34	33	34
2025	4	4	17	22	55	0.656	-0.092	3.465	0.013	0.01	0	42.1	32.3	74	133	108	0	35	33	34
2025	4	4	17	32	55	0.666	-0.098	3.465	0.01	0.007	0	41.7	31.4	74.4	132	106	0	35	33	34
2025	4	4	17	42	55	0.666	-0.079	3.465	0.016	0.013	0	41.7	30.5	74.4	132	105	0	35	34	34
2025	4	4	17	52	55	0.673	-0.072	3.465	0.01	0.007	0	41.7	31	73.5	131	105	0	34	33	34
2025	4	4	18	2	55	0.673	-0.075	3.468	0.013	0.01	0	43.4	33.1	72.7	135	110	0	34	33	33
2025	4	4	18	12	55	0.702	-0.062	3.465	0.01	0.007	0	43	32.7	73.5	135	110	0	35	34	34
2025	4	4	18	22	55	0.702	-0.085	3.468	0.01	0.007	0	43	32.7	74.4	134	110	0	34	34	34
2025	4	4	18	32	55	0.715	-0.102	3.468	0.01	0.007	0	42.6	33.1	74.4	134	110	0	35	33	34
2025	4	4	18	42	55	0.696	-0.102	3.465	0.013	0.01	0	43	33.1	74.4	135	110	0	35	33	34
2025	4	4	18	52	55	0.728	-0.089	3.468	0.01	0.007	0	43	33.1	74	135	111	0	35	34	34
2025	4	4	19	2	55	0.705	-0.092	3.468	0.01	0.007	0	43.9	33.5	73.5	136	111	0	34	33	35
2025	4	4	19	12	55	0.689	-0.118	3.468	0.01	0.007	0	43.9	34.4	74	137	113	0	35	33	34
2025	4	4	19	22	55	0.676	-0.095	3.468	0.01	0.007	0	43.9	34	73.5	137	113	0	35	34	34
2025	4	4	19	32	55	0.646	-0.066	3.468	0.016	0.013	0	44.3	34	73.1	137	112	0	34	33	35
2025	4	4	19	42	55	0.653	-0.089	3.468	0.016	0.013	0	44.3	34.4	73.1	138	113	0	35	33	34
2025	4	4	19	52	55	0.722	-0.092	3.468	0.013	0.01	0	45.2	34.8	72.7	139	114	0	34	33	35
2025	4	4	20	2	55	0.682	-0.075	3.468	0.016	0.013	0	45.2	34.8	71.8	140	115	0	35	34	34
2025	4	4	20	12	55	0.735	-0.089	3.468	0.013	0.01	0	44.3	34.4	65.8	138	113	0	35	33	34
2025	4	4	20	22	55	0.663	-0.075	3.465	0.016	0.013	0	44.3	34.4	55.5	138	113	0	35	33	34
2025	4	4	20	32	55	0.673	-0.089	3.468	0.016	0.013	0	44.3	34.4	64.5	138	114	0	35	34	34
2025	4	4	20	42	55	0.659	-0.046	3.468	0.016	0.016	0	44.3	34.8	64.1	138	114	0	35	33	34
2025	4	4	20	52	55	0.692	-0.082	3.468	0.013	0.01	0	44.7	34.4	59.3	139	114	0	35	34	34
2025	4	4	21	2	55	0.666	-0.089	3.468	0.013	0.01	0	45.2	34.4	54.2	140	114	0	35	34	34
2025	4	4	21	12	55	0.689	-0.095	3.471	0.01	0.007	0	44.3	34	52.9	138	113	0	35	34	34
2025	4	4	21	22	55	0.689	-0.102	3.471	0.01	0.007	0	44.7	34.4	54.2	139	114	0	35	34	34
2025	4	4	21	32	55	0.676	-0.089	3.474	0.016	0.016	0	45.2	34.8	51.6	139	114	0	34	33	34
2025	4	4	21	42	55	0.607	-0.089	3.474	0.013	0.01	0	45.6	35.3	51.6	140	115	0	34	33	34
2025	4	4	21	52	55	0.679	-0.128	3.474	0.013	0.01	0	44.7	34.4	55.9	139	114	0	35	34	34
2025	4	4	22	2	55	0.669	-0.095	3.474	0.013	0.01	0	44.3	34.4	57.2	138	113	0	35	33	34
2025	4	4	22	12	55	0.673	-0.089	3.478	0.01	0.007	0	45.2	35.3	70.1	140	115	0	35	33	35
2025	4	4	22	22	55	0.673	-0.095	3.478	0.013	0.01	0	44.7	34.4	71	139	114	0	35	34	34
2025	4	4	22	32	55	0.709	-0.108	3.481	0.016	0.013	0	45.2	34.8	62.8	139	114	0	34	33	35
2025	4	4	22	42	55	0.699	-0.069	3.481	0.01	0.007	0	44.7	34	71.4	139	113	0	35	34	34
2025	4	4	22	52	55	0.689	-0.079	3.481	0.016	0.013	0	44.7	34	74.4	138	113	0	34	34	35
2025	4	4	23	2	55	0.692	-0.108	3.481	0.013	0.01	0	44.7	34.4	74	139	114	0	35	34	34
2025	4	4	23	12	55	0.679	-0.085	3.481	0.016	0.013	0	44.7	34.8	74	139	114	0	35	33	34
2025	4	4	23	22	55	0.682	-0.121	3.481	0.016	0.013	0	45.2	34.8	73.1	140	114	0	35	33	35
2025	4	4	23	32	55	0.705	-0.102	3.481	0.016	0.013	0	44.7	34.4	74.4	139	114	0	35	34	35
2025	4	4	23	42	55	0.656	-0.085	3.484	0.01	0.007	0	45.2	34.8	71.8	140	115	0	35	34	34
2025	4	4	23	52	55	0.676	-0.092	3.484	0.01	0.007	0	45.2	34.4	74.8	139	114	0	34	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	5	0	2	55	0.676	-0.059	3.484	0.013	0.01	0	44.7	34.4	71	139	114	0	35	34	34
2025	4	5	0	12	55	0.676	-0.082	3.484	0.016	0.013	0	44.7	34	74.8	139	113	0	35	34	34
2025	4	5	0	22	55	0.728	-0.092	3.484	0.013	0.01	0	44.3	34	75.3	138	113	0	35	34	34
2025	4	5	0	32	55	0.719	-0.092	3.484	0.013	0.01	0	44.3	34	74.8	138	113	0	35	34	34
2025	4	5	0	42	55	0.679	-0.059	3.484	0.016	0.016	0	44.3	34.4	72.2	138	113	0	35	33	34
2025	4	5	0	52	55	0.705	-0.092	3.484	0.013	0.01	0	43.9	33.5	74.8	137	112	0	35	34	34
2025	4	5	1	2	55	0.692	-0.092	3.484	0.013	0.01	0	44.3	34	74	138	112	0	35	33	34
2025	4	5	1	12	55	0.679	-0.085	3.488	0.01	0.007	0	43.9	33.5	73.1	137	112	0	35	34	35
2025	4	5	1	22	55	0.705	-0.131	3.488	0.013	0.01	0	43.9	33.5	73.1	137	112	0	35	34	35
2025	4	5	1	32	55	0.646	-0.079	3.488	0.013	0.01	0	43.9	33.5	73.1	137	112	0	35	34	35
2025	4	5	1	42	55	0.663	-0.052	3.488	0.01	0.007	0	43.9	33.5	72.2	137	112	0	35	34	35
2025	4	5	1	52	55	0.659	-0.125	3.488	0.01	0.007	0	44.3	34	71.8	138	113	0	35	34	35
2025	4	5	2	2	55	0.689	-0.079	3.488	0.016	0.013	0	44.3	33.5	71.4	138	112	0	35	34	35
2025	4	5	2	12	55	0.705	-0.072	3.491	0.01	0.007	0	44.3	34.4	72.2	138	113	0	35	33	34
2025	4	5	2	22	55	0.679	-0.092	3.491	0.01	0.007	0	44.3	34	65.8	138	113	0	35	34	35
2025	4	5	2	32	55	0.696	-0.098	3.491	0.013	0.01	0	43.9	34.8	53.8	137	115	0	35	34	35
2025	4	5	2	42	55	0.673	-0.089	3.494	0.016	0.013	0	44.3	34.8	60.2	138	115	0	35	34	35
2025	4	5	2	52	55	0.705	-0.102	3.497	0.016	0.013	0	44.3	34.8	50.3	138	115	0	35	34	34
2025	4	5	3	2	55	0.686	-0.092	3.501	0.01	0.007	0	44.3	35.3	63.2	138	116	0	35	34	35
2025	4	5	3	12	55	0.669	-0.049	3.504	0.016	0.013	0	44.7	35.7	54.6	139	117	0	35	34	34
2025	4	5	3	22	55	0.699	-0.105	3.507	0.013	0.01	0	43	34.4	71.4	136	114	0	36	34	35
2025	4	5	3	32	55	0.696	-0.082	3.507	0.01	0.007	0	44.3	35.3	70.5	138	116	0	35	34	35
2025	4	5	3	42	55	0.705	-0.108	3.507	0.016	0.013	0	43.9	34.8	60.2	137	115	0	35	34	34
2025	4	5	3	52	55	0.676	-0.062	3.507	0.013	0.01	0	43.9	34.8	49.5	137	115	0	35	34	35
2025	4	5	4	2	55	0.699	-0.069	3.51	0.013	0.01	0	44.3	35.3	74.8	138	116	0	35	34	34
2025	4	5	4	12	55	0.696	-0.092	3.51	0.013	0.01	0	44.3	34.4	73.5	138	115	0	35	35	34
2025	4	5	4	22	55	0.712	-0.075	3.51	0.013	0.01	0	44.3	35.3	58	138	116	0	35	34	35
2025	4	5	4	32	55	0.709	-0.079	3.514	0.013	0.01	0	43.4	34.4	71	137	114	0	36	34	34
2025	4	5	4	42	55	0.666	-0.102	3.514	0.013	0.01	0	44.3	35.3	74.8	138	115	0	35	33	34
2025	4	5	4	52	55	0.699	-0.098	3.514	0.013	0.01	0	44.3	35.3	75.3	138	116	0	35	34	35
2025	4	5	5	2	55	0.682	-0.115	3.514	0.016	0.013	0	43.9	34.8	74.4	137	115	0	35	34	35
2025	4	5	5	12	55	0.705	-0.108	3.514	0.016	0.013	0	43.4	34.4	74.8	136	114	0	35	34	34
2025	4	5	5	22	55	0.673	-0.098	3.517	0.01	0.007	0	43.9	34.8	73.5	137	115	0	35	34	35
2025	4	5	5	32	55	0.715	-0.102	3.517	0.01	0.007	0	43.9	35.7	67.9	137	117	0	35	34	34
2025	4	5	5	42	55	0.682	-0.056	3.517	0.013	0.01	0	44.7	35.7	64.1	139	118	0	35	35	34
2025	4	5	5	52	55	0.722	-0.066	3.517	0.013	0.01	0	45.2	36.5	74.4	140	119	0	35	34	35
2025	4	5	6	2	55	0.696	-0.082	3.517	0.013	0.01	0	45.2	36.5	73.5	140	119	0	35	34	34
2025	4	5	6	12	55	0.666	-0.056	3.52	0.01	0.007	0	45.2	36.5	74	140	119	0	35	34	35
2025	4	5	6	22	55	0.676	-0.069	3.52	0.016	0.013	0	44.7	36.1	74.4	139	118	0	35	34	34
2025	4	5	6	32	55	0.699	-0.098	3.52	0.01	0.007	0	45.2	36.1	55	140	119	0	35	35	35
2025	4	5	6	42	55	0.738	-0.128	3.524	0.01	0.007	0	44.3	35.7	69.7	138	117	0	35	34	34
2025	4	5	6	52	55	0.669	-0.098	3.524	0.01	0.007	0	44.7	35.7	58.5	138	117	0	34	34	34
2025	4	5	7	2	55	0.705	-0.075	3.524	0.01	0.007	0	43.9	35.3	53.8	137	117	0	35	35	35
2025	4	5	7	12	55	0.692	-0.079	3.527	0.016	0.016	0	43	34.8	71.4	135	115	0	35	34	34
2025	4	5	7	22	55	0.686	-0.098	3.53	0.013	0.01	0	44.7	36.5	51.6	139	119	0	35	34	35
2025	4	5	7	32	55	0.732	-0.102	3.537	0.013	0.01	0	42.6	34.8	51.6	134	115	0	35	34	35
2025	4	5	7	42	55	0.719	-0.105	3.54	0.016	0.016	0	44.3	36.1	56.3	138	118	0	35	34	35
2025	4	5	7	52	55	0.732	-0.128	3.543	0.01	0.007	0	43	35.3	50.3	135	116	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	5	8	2	55	0.755	-0.118	3.543	0.016	0.013	0	43	34.8	50.7	135	115	0	35	34	34
2025	4	5	8	12	55	0.728	-0.075	3.547	0.01	0.007	0	43.4	35.3	50.3	136	116	0	35	34	35
2025	4	5	8	22	55	0.715	-0.112	3.547	0.013	0.01	0	43.9	36.1	48.6	138	118	0	36	34	35
2025	4	5	8	32	55	0.728	-0.082	3.547	0.01	0.007	0	44.3	36.1	49.9	138	118	0	35	34	34
2025	4	5	8	42	55	0.745	-0.092	3.55	0.013	0.01	0	43.9	36.1	50.7	137	118	0	35	34	35
2025	4	5	8	52	55	0.728	-0.082	3.553	0.013	0.01	0	43.4	35.7	49.5	136	117	0	35	34	35
2025	4	5	9	2	55	0.735	-0.121	3.553	0.01	0.007	0	43	35.7	50.7	135	116	0	35	33	34
2025	4	5	9	12	55	0.669	-0.085	3.553	0.013	0.01	0	44.3	37	49.9	138	119	0	35	33	34
2025	4	5	9	22	55	0.732	-0.105	3.556	0.01	0.007	0	44.3	36.5	49.5	138	119	0	35	34	35
2025	4	5	9	32	55	0.709	-0.085	3.56	0.013	0.01	0	43.4	35.7	50.7	136	117	0	35	34	35
2025	4	5	9	42	55	0.725	-0.121	3.56	0.013	0.01	0	43.4	36.1	51.2	136	117	0	35	33	35
2025	4	5	9	52	55	0.705	-0.095	3.56	0.013	0.01	0	44.3	36.5	52.5	138	119	0	35	34	34
2025	4	5	10	2	55	0.725	-0.098	3.563	0.01	0.007	0	43.9	36.1	51.2	137	117	0	35	33	34
2025	4	5	10	12	55	0.722	-0.115	3.566	0.016	0.016	0	43.9	35.7	50.7	137	117	0	35	34	35
2025	4	5	10	22	55	0.761	-0.085	3.566	0.013	0.01	0	43.4	35.3	52.5	136	116	0	35	34	35
2025	4	5	10	32	55	0.725	-0.102	3.57	0.013	0.01	0	43.4	35.7	49.9	136	117	0	35	34	34
2025	4	5	10	42	55	0.719	-0.056	3.57	0.01	0.007	0	44.3	36.5	52.5	138	118	0	35	33	34
2025	4	5	10	52	55	0.755	-0.095	3.57	0.013	0.01	0	43.9	36.1	52	137	118	0	35	34	34
2025	4	5	11	2	55	0.719	-0.059	3.573	0.013	0.01	0	43.9	35.7	52.5	137	117	0	35	34	34
2025	4	5	11	12	55	0.787	-0.095	3.573	0.01	0.007	0	43.9	36.1	49.9	137	117	0	35	33	34
2025	4	5	11	22	55	0.719	-0.085	3.576	0.01	0.007	0	42.6	34.8	50.7	135	115	0	36	34	35
2025	4	5	11	32	55	0.686	-0.105	3.576	0.013	0.01	0	43	34.4	54.2	134	114	0	34	34	34
2025	4	5	11	42	55	0.751	-0.115	3.579	0.013	0.01	0	43	34.8	52.9	135	115	0	35	34	34
2025	4	5	11	52	55	0.761	-0.102	3.579	0.013	0.01	0	42.1	34.8	49.9	133	114	0	35	33	34
2025	4	5	12	2	55	0.725	-0.092	3.583	0.013	0.01	0	43.9	35.7	49	136	117	0	34	34	34
2025	4	5	12	12	55	0.738	-0.089	3.586	0.016	0.013	0	43	35.7	49.9	135	116	0	35	33	34
2025	4	5	12	22	55	0.692	-0.102	3.589	0.01	0.007	0	43.9	36.1	50.3	137	118	0	35	34	34
2025	4	5	12	32	55	0.748	-0.079	3.589	0.01	0.007	0	43	35.3	52.5	135	116	0	35	34	34
2025	4	5	12	42	55	0.751	-0.085	3.589	0.013	0.01	0	43	35.3	51.2	135	116	0	35	34	34
2025	4	5	12	52	55	0.751	-0.125	3.596	0.016	0.013	0	43.4	35.7	54.6	136	117	0	35	34	34
2025	4	5	13	2	55	0.745	-0.095	3.596	0.013	0.01	0	43.4	36.1	53.3	136	117	0	35	33	34
2025	4	5	13	12	55	0.791	-0.085	3.599	0.01	0.007	0	43.4	35.7	56.3	136	117	0	35	34	34
2025	4	5	13	22	55	0.722	-0.118	3.599	0.013	0.01	0	44.3	36.1	55	137	118	0	34	34	34
2025	4	5	13	32	55	0.748	-0.108	3.602	0.013	0.01	0	43.4	36.1	60.2	136	117	0	35	33	35
2025	4	5	13	42	55	0.705	-0.089	3.606	0.016	0.013	0	43.4	36.1	73.5	136	117	0	35	33	34
2025	4	5	13	52	55	0.732	-0.082	3.606	0.013	0.01	0	43.4	36.1	72.2	136	117	0	35	33	34
2025	4	5	14	2	55	0.738	-0.102	3.609	0.013	0.01	0	43	35.3	66.7	135	116	0	35	34	34
2025	4	5	14	12	55	0.748	-0.098	3.609	0.01	0.007	0	43.4	36.1	64.1	135	117	0	34	33	34
2025	4	5	14	22	55	0.712	-0.062	3.609	0.013	0.01	0	44.3	37	59.3	137	119	0	34	33	34
2025	4	5	14	32	55	0.738	-0.092	3.609	0.013	0.01	0	44.3	37	72.7	138	120	0	35	34	34
2025	4	5	14	42	55	0.735	-0.089	3.612	0.013	0.01	0	44.3	37	75.7	137	119	0	34	33	34
2025	4	5	14	52	55	0.692	-0.102	3.612	0.016	0.013	0	43.9	37	68.4	137	119	0	35	33	34
2025	4	5	15	2	55	0.719	-0.085	3.612	0.016	0.013	0	45.2	37.8	75.3	139	121	0	34	33	34
2025	4	5	15	12	55	0.794	-0.131	3.612	0.01	0.007	0	43.4	36.5	74.4	136	118	0	35	33	35
2025	4	5	15	22	55	0.728	-0.102	3.615	0.016	0.013	0	43.9	37	74.4	137	120	0	35	34	34
2025	4	5	15	32	55	0.719	-0.085	3.615	0.01	0.007	0	44.3	37.4	74	137	119	0	34	32	34
2025	4	5	15	42	55	0.735	-0.095	3.615	0.013	0.01	0	43.9	37.4	71.8	137	120	0	35	33	34
2025	4	5	15	52	55	0.732	-0.075	3.619	0.013	0.01	0	43.4	36.5	62.4	136	118	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	5	16	2	55	0.771	-0.085	3.619	0.016	0.016	0	43	37	74.8	135	118	0	35	32	35
2025	4	5	16	12	55	0.728	-0.085	3.619	0.01	0.007	0	43.4	36.5	74.4	136	118	0	35	33	34
2025	4	5	16	22	55	0.791	-0.135	3.622	0.01	0.007	0	43.9	36.1	74.4	136	118	0	34	34	33
2025	4	5	16	32	55	0.741	-0.089	3.622	0.013	0.01	0	43.4	37	73.5	136	118	0	35	32	34
2025	4	5	16	42	55	0.778	-0.079	3.622	0.01	0.007	0	43.4	36.1	73.5	136	118	0	35	34	34
2025	4	5	16	52	55	0.741	-0.105	3.625	0.01	0.007	0	43	35.7	72.2	134	116	0	34	33	35
2025	4	5	17	2	55	0.771	-0.082	3.625	0.01	0.007	0	42.6	35.3	72.7	134	116	0	35	34	34
2025	4	5	17	12	55	0.771	-0.075	3.629	0.013	0.01	0	43.4	35.7	72.2	135	117	0	34	34	34
2025	4	5	17	22	55	0.735	-0.085	3.632	0.01	0.007	0	43.4	36.1	71.8	135	117	0	34	33	34
2025	4	5	17	32	55	0.741	-0.062	3.638	0.013	0.01	0	42.6	36.1	72.7	134	117	0	35	33	34
2025	4	5	17	42	55	0.741	-0.072	3.642	0.013	0.01	0	42.6	35.7	74	133	116	0	34	33	34
2025	4	5	17	52	55	0.689	-0.075	3.642	0.016	0.013	0	42.6	35.7	74.4	133	116	0	34	33	34
2025	4	5	18	2	55	0.732	-0.082	3.645	0.01	0.007	0	43	36.1	74	135	117	0	35	33	34
2025	4	5	18	12	55	0.761	-0.089	3.645	0.01	0.007	0	43	34.8	75.7	134	115	0	34	34	34
2025	4	5	18	22	55	0.745	-0.079	3.648	0.016	0.013	0	42.1	35.3	76.1	133	115	0	35	33	34
2025	4	5	18	32	55	0.709	-0.085	3.648	0.013	0.01	0	43	35.3	76.1	134	116	0	34	34	34
2025	4	5	18	42	55	0.794	-0.079	3.648	0.01	0.007	0	42.6	35.3	75.7	134	116	0	35	34	34
2025	4	5	18	52	55	0.722	-0.092	3.648	0.01	0.007	0	43	35.7	76.1	135	117	0	35	34	34
2025	4	5	19	2	55	0.794	-0.062	3.648	0.013	0.01	0	43	36.1	75.7	135	117	0	35	33	35
2025	4	5	19	12	55	0.728	-0.052	3.652	0.01	0.007	0	44.3	37	75.7	137	119	0	34	33	34
2025	4	5	19	22	55	0.732	-0.056	3.652	0.013	0.01	0	44.3	37	75.7	137	119	0	34	33	34
2025	4	5	19	32	55	0.741	-0.082	3.652	0.01	0.007	0	43.9	36.5	75.3	137	119	0	35	34	34
2025	4	5	19	42	55	0.745	-0.089	3.652	0.01	0.007	0	44.7	37.4	74.4	138	120	0	34	33	34
2025	4	5	19	52	55	0.771	-0.056	3.652	0.016	0.016	0	44.3	37.4	74.4	138	120	0	35	33	35
2025	4	5	20	2	55	0.771	-0.052	3.655	0.013	0.01	0	43.9	37	74	137	119	0	35	33	34
2025	4	5	20	12	55	0.735	-0.095	3.655	0.016	0.016	0	44.3	37.4	73.5	138	120	0	35	33	34
2025	4	5	20	22	55	0.719	-0.102	3.655	0.016	0.016	0	44.7	37.4	71.8	139	120	0	35	33	34
2025	4	5	20	32	55	0.725	-0.098	3.655	0.01	0.007	0	46	39.1	67.9	142	124	0	35	33	34
2025	4	5	20	42	55	0.764	-0.066	3.658	0.016	0.013	0	45.2	37.4	71.4	140	121	0	35	34	34
2025	4	5	20	52	55	0.748	-0.108	3.661	0.01	0.007	0	44.3	37.4	71.4	138	120	0	35	33	34
2025	4	5	21	2	55	0.748	-0.072	3.668	0.013	0.01	0	44.7	37.4	71	139	121	0	35	34	34
2025	4	5	21	12	55	0.755	-0.105	3.671	0.01	0.007	0	44.3	36.5	73.1	137	119	0	34	34	34
2025	4	5	21	22	55	0.761	-0.075	3.671	0.013	0.01	0	44.7	37.4	70.5	139	121	0	35	34	34
2025	4	5	21	32	55	0.745	-0.115	3.675	0.01	0.007	0	44.3	36.5	74	137	119	0	34	34	35
2025	4	5	21	42	55	0.755	-0.095	3.675	0.013	0.01	0	43.9	37.4	74.8	137	120	0	35	33	34
2025	4	5	21	52	55	0.774	-0.069	3.675	0.01	0.007	0	43.9	36.5	74	137	119	0	35	34	35
2025	4	5	22	2	55	0.778	-0.085	3.675	0.016	0.013	0	44.3	37	75.3	138	119	0	35	33	34
2025	4	5	22	12	55	0.778	-0.108	3.675	0.013	0.01	0	45.2	37	75.3	139	119	0	34	33	34
2025	4	5	22	22	55	0.758	-0.098	3.675	0.01	0.007	0	44.7	37	74	139	119	0	35	33	35
2025	4	5	22	32	55	0.764	-0.095	3.678	0.01	0.007	0	45.2	36.5	72.2	139	119	0	34	34	34
2025	4	5	22	42	55	0.761	-0.082	3.678	0.013	0.01	0	44.7	37	74	139	120	0	35	34	35
2025	4	5	22	52	55	0.784	-0.102	3.678	0.01	0.007	0	44.7	37	74.8	139	119	0	35	33	35
2025	4	5	23	2	55	0.778	-0.102	3.678	0.016	0.013	0	45.2	37	72.2	140	120	0	35	34	34
2025	4	5	23	12	55	0.771	-0.102	3.678	0.013	0.01	0	44.7	37	74.4	139	119	0	35	33	34
2025	4	5	23	22	55	0.794	-0.085	3.681	0.01	0.007	0	44.3	36.5	74	138	119	0	35	34	34
2025	4	5	23	32	55	0.751	-0.098	3.681	0.013	0.01	0	44.7	37	73.1	139	120	0	35	34	34
2025	4	5	23	42	55	0.751	-0.115	3.681	0.01	0.007	0	44.3	36.5	72.7	138	119	0	35	34	35
2025	4	5	23	52	55	0.771	-0.115	3.684	0.013	0.01	0	44.3	37	71.8	138	119	0	35	33	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	6	0	2	55	0.768	-0.112	3.684	0.01	0.007	0	44.3	36.5	71.4	138	119	0	35	34	35
2025	4	6	0	12	55	0.755	-0.085	3.688	0.01	0.007	0	43.9	36.1	70.5	137	118	0	35	34	35
2025	4	6	0	22	55	0.751	-0.089	3.694	0.013	0.01	0	44.3	36.5	71.8	138	119	0	35	34	34
2025	4	6	0	32	55	0.748	-0.105	3.698	0.01	0.007	0	43.9	36.5	71.4	137	118	0	35	33	35
2025	4	6	0	42	55	0.748	-0.095	3.698	0.016	0.013	0	44.3	36.5	72.2	138	119	0	35	34	34
2025	4	6	0	52	55	0.774	-0.072	3.701	0.013	0.01	0	43.9	36.5	72.7	137	118	0	35	33	35
2025	4	6	1	2	55	0.82	-0.115	3.701	0.013	0.01	0	43.9	36.1	73.1	137	118	0	35	34	35
2025	4	6	1	12	55	0.764	-0.079	3.701	0.01	0.007	0	43.9	36.1	74	137	118	0	35	34	35
2025	4	6	1	22	55	0.738	-0.102	3.701	0.016	0.013	0	43.9	36.1	74.4	137	118	0	35	34	35
2025	4	6	1	32	55	0.741	-0.089	3.704	0.016	0.013	0	44.3	36.5	76.1	138	119	0	35	34	34
2025	4	6	1	42	55	0.751	-0.089	3.704	0.016	0.013	0	44.3	36.1	75.7	138	118	0	35	34	35
2025	4	6	1	52	55	0.764	-0.082	3.704	0.016	0.016	0	43.9	36.1	75.3	137	118	0	35	34	35
2025	4	6	2	2	55	0.761	-0.095	3.704	0.013	0.01	0	44.3	36.5	74.8	138	119	0	35	34	35
2025	4	6	2	12	55	0.774	-0.082	3.704	0.013	0.01	0	44.3	36.1	74.8	138	118	0	35	34	35
2025	4	6	2	22	55	0.781	-0.102	3.704	0.01	0.007	0	44.3	36.1	74.4	138	118	0	35	34	35
2025	4	6	2	32	55	0.774	-0.089	3.704	0.016	0.013	0	43.9	36.5	74	138	118	0	36	33	35
2025	4	6	2	42	55	0.768	-0.098	3.707	0.01	0.007	0	44.3	36.1	74.4	138	118	0	35	34	34
2025	4	6	2	52	55	0.791	-0.082	3.707	0.01	0.007	0	44.7	37	74.4	139	119	0	35	33	34
2025	4	6	3	2	55	0.758	-0.098	3.707	0.016	0.013	0	43.9	36.5	74.8	137	118	0	35	33	34
2025	4	6	3	12	55	0.781	-0.075	3.707	0.01	0.007	0	44.7	36.5	74.4	139	119	0	35	34	34
2025	4	6	3	22	55	0.758	-0.085	3.707	0.01	0.007	0	44.3	36.1	74.4	138	118	0	35	34	35
2025	4	6	3	32	55	0.784	-0.072	3.711	0.01	0.007	0	44.3	36.5	74.4	138	119	0	35	34	35
2025	4	6	3	42	55	0.791	-0.082	3.711	0.01	0.007	0	45.2	36.5	74.4	139	119	0	34	34	35
2025	4	6	3	52	55	0.807	-0.085	3.711	0.01	0.007	0	44.3	36.5	74	138	118	0	35	33	34
2025	4	6	4	2	55	0.745	-0.105	3.711	0.01	0.007	0	43.9	36.1	75.3	138	118	0	36	34	34
2025	4	6	4	12	55	0.771	-0.115	3.711	0.013	0.01	0	44.7	36.1	74.4	138	118	0	34	34	35
2025	4	6	4	22	55	0.794	-0.079	3.711	0.01	0.007	0	44.7	37	74.8	139	120	0	35	34	34
2025	4	6	4	32	55	0.761	-0.069	3.711	0.013	0.01	0	44.3	36.1	74.4	138	118	0	35	34	34
2025	4	6	4	42	55	0.781	-0.092	3.711	0.013	0.01	0	44.3	36.1	74	138	118	0	35	34	34
2025	4	6	4	52	55	0.801	-0.115	3.714	0.01	0.007	0	43.4	35.7	73.1	136	117	0	35	34	35
2025	4	6	5	2	55	0.768	-0.095	3.714	0.01	0.007	0	43.9	35.7	74	137	117	0	35	34	34
2025	4	6	5	12	55	0.791	-0.108	3.714	0.013	0.01	0	43.9	36.5	73.1	137	118	0	35	33	35
2025	4	6	5	22	55	0.745	-0.112	3.714	0.013	0.01	0	43.9	36.5	73.5	137	118	0	35	33	34
2025	4	6	5	32	55	0.781	-0.092	3.714	0.013	0.01	0	44.7	37	73.5	138	119	0	34	33	34
2025	4	6	5	42	55	0.735	-0.085	3.714	0.013	0.01	0	44.3	37	72.7	138	119	0	35	33	35
2025	4	6	5	52	55	0.755	-0.069	3.714	0.01	0.007	0	43.4	35.7	72.2	136	117	0	35	34	35
2025	4	6	6	2	55	0.781	-0.085	3.714	0.01	0.007	0	43.9	35.7	72.7	137	117	0	35	34	34
2025	4	6	6	12	55	0.794	-0.105	3.717	0.013	0.01	0	42.1	35.3	72.7	133	116	0	35	34	35
2025	4	6	6	22	55	0.784	-0.079	3.717	0.01	0.007	0	43.4	35.7	72.2	136	116	0	35	33	35
2025	4	6	6	32	55	0.741	-0.079	3.717	0.016	0.016	0	42.6	35.3	73.5	134	115	0	35	33	33
2025	4	6	6	42	55	0.791	-0.069	3.717	0.013	0.01	0	42.6	34.8	72.7	134	115	0	35	34	35
2025	4	6	6	52	55	0.83	-0.105	3.72	0.01	0.007	0	43	34.8	72.7	135	115	0	35	34	35
2025	4	6	7	2	55	0.771	-0.092	3.72	0.01	0.007	0	43	35.3	72.7	135	116	0	35	34	34
2025	4	6	7	12	55	0.791	-0.108	3.72	0.013	0.01	0	42.6	34.8	72.7	134	115	0	35	34	34
2025	4	6	7	22	55	0.751	-0.056	3.72	0.01	0.007	0	43.9	35.7	71.8	137	117	0	35	34	35
2025	4	6	7	32	55	0.768	-0.089	3.72	0.016	0.016	0	43.4	36.5	71.8	137	118	0	36	33	35
2025	4	6	7	42	55	0.778	-0.105	3.724	0.01	0.007	0	42.6	34.8	72.2	134	115	0	35	34	34
2025	4	6	7	52	55	0.778	-0.112	3.724	0.013	0.01	0	42.1	34.4	71.8	133	115	0	35	35	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	6	8	2	55	0.778	-0.059	3.724	0.01	0.007	0	43	35.7	71.8	135	116	0	35	33	35
2025	4	6	8	12	55	0.728	-0.082	3.724	0.01	0.007	0	43.4	36.1	71.8	136	118	0	35	34	35
2025	4	6	8	22	55	0.794	-0.095	3.727	0.01	0.007	0	43.9	36.1	71.8	137	118	0	35	34	34
2025	4	6	8	32	55	0.81	-0.148	3.724	0.01	0.007	0	43.9	36.1	71.8	137	118	0	35	34	35
2025	4	6	8	42	55	0.738	-0.079	3.727	0.01	0.007	0	43	35.7	71.4	136	117	0	36	34	34
2025	4	6	8	52	55	0.817	-0.098	3.727	0.013	0.01	0	42.6	35.3	72.7	134	115	0	35	33	34
2025	4	6	9	2	55	0.781	-0.128	3.727	0.01	0.007	0	42.6	35.3	73.1	134	116	0	35	34	34
2025	4	6	9	12	55	0.771	-0.082	3.724	0.01	0.007	0	42.6	34.8	73.1	134	115	0	35	34	34
2025	4	6	9	22	55	0.781	-0.131	3.727	0.01	0.007	0	42.6	34.8	73.1	134	115	0	35	34	35
2025	4	6	9	32	55	0.807	-0.095	3.727	0.01	0.007	0	43	34.8	73.5	135	115	0	35	34	34
2025	4	6	9	42	55	0.801	-0.095	3.727	0.013	0.01	0	43	35.3	72.7	134	115	0	34	33	34
2025	4	6	9	52	55	0.728	-0.112	3.727	0.01	0.007	0	42.6	35.3	73.5	134	115	0	35	33	34
2025	4	6	10	2	55	0.797	-0.089	3.727	0.01	0.007	0	42.6	34.8	70.1	134	115	0	35	34	35
2025	4	6	10	12	55	0.741	-0.118	3.727	0.01	0.007	0	41.7	34.4	74.4	132	113	0	35	33	35
2025	4	6	10	22	55	0.801	-0.085	3.727	0.013	0.01	0	43	35.3	73.5	134	115	0	34	33	35
2025	4	6	10	32	55	0.755	-0.098	3.727	0.016	0.013	0	41.7	34	74.4	132	113	0	35	34	34
2025	4	6	10	42	55	0.774	-0.095	3.73	0.013	0.01	0	42.1	35.3	74.4	133	115	0	35	33	34
2025	4	6	10	52	55	0.755	-0.085	3.727	0.01	0.007	0	42.1	34.8	74	133	114	0	35	33	35
2025	4	6	11	2	55	0.751	-0.069	3.73	0.01	0.007	0	42.6	35.7	72.7	134	116	0	35	33	35
2025	4	6	11	12	55	0.778	-0.092	3.727	0.013	0.01	0	42.1	34	74.4	133	113	0	35	34	34
2025	4	6	11	22	55	0.784	-0.102	3.727	0.01	0.007	0	42.1	34.4	59.8	133	114	0	35	34	34
2025	4	6	11	32	55	0.778	-0.108	3.73	0.02	0.016	0	42.1	34.8	73.5	133	114	0	35	33	34
2025	4	6	11	42	55	0.804	-0.098	3.727	0.013	0.01	0	41.7	34.8	64.5	132	114	0	35	33	34
2025	4	6	11	52	55	0.764	-0.066	3.73	0.013	0.01	0	42.6	34.4	51.2	133	114	0	34	34	34
2025	4	6	12	2	55	0.758	-0.115	3.727	0.013	0.01	0	41.3	34	56.3	131	112	0	35	33	34
2025	4	6	12	12	55	0.794	-0.121	3.73	0.013	0.01	0	42.1	34.8	59.8	133	114	0	35	33	34
2025	4	6	12	22	55	0.745	-0.056	3.73	0.013	0.01	0	42.6	34.8	48.6	133	114	0	34	33	34
2025	4	6	12	32	55	0.764	-0.102	3.73	0.013	0.01	0	41.7	34	56.3	132	113	0	35	34	34
2025	4	6	12	42	55	0.794	-0.085	3.73	0.01	0.007	0	41.7	34.4	63.6	132	114	0	35	34	34
2025	4	6	12	52	55	0.755	-0.095	3.73	0.01	0.007	0	41.7	34.8	48.6	132	114	0	35	33	34
2025	4	6	13	2	55	0.781	-0.092	3.73	0.01	0.007	0	42.1	35.3	54.2	133	115	0	35	33	34
2025	4	6	13	12	55	0.784	-0.085	3.73	0.013	0.01	0	41.7	34.4	49.9	132	114	0	35	34	34
2025	4	6	13	22	55	0.732	-0.098	3.73	0.013	0.01	0	42.1	34	50.3	132	112	0	34	33	35
2025	4	6	13	32	55	0.741	-0.062	3.73	0.013	0.01	0	42.1	34.8	50.7	133	114	0	35	33	34
2025	4	6	13	42	55	0.781	-0.108	3.73	0.01	0.007	0	42.1	34.8	45.2	133	115	0	35	34	35
2025	4	6	13	52	55	0.787	-0.095	3.727	0.016	0.013	0	42.1	34.4	47.7	133	114	0	35	34	34
2025	4	6	14	2	55	0.784	-0.095	3.73	0.013	0.01	0	42.1	35.3	49.5	132	114	0	34	32	33
2025	4	6	14	12	55	0.748	-0.102	3.727	0.013	0.01	0	42.1	34.8	47.3	133	114	0	35	33	34
2025	4	6	14	22	55	0.741	-0.072	3.727	0.013	0.01	0	42.1	34.4	49.5	133	114	0	35	34	34
2025	4	6	14	32	55	0.774	-0.069	3.727	0.013	0.01	0	42.6	35.7	47.3	134	116	0	35	33	34
2025	4	6	14	42	55	0.755	-0.075	3.727	0.01	0.007	0	42.1	35.3	51.6	133	115	0	35	33	34
2025	4	6	14	52	55	0.774	-0.108	3.727	0.013	0.01	0	42.1	34.8	55.5	133	114	0	35	33	35
2025	4	6	15	2	55	0.791	-0.079	3.727	0.01	0.007	0	42.6	34.4	48.2	133	114	0	34	34	34
2025	4	6	15	12	55	0.758	-0.079	3.724	0.013	0.01	0	42.6	34.4	49	133	114	0	34	34	34
2025	4	6	15	22	55	0.771	-0.072	3.724	0.01	0.007	0	42.1	34.8	49.9	133	114	0	35	33	34
2025	4	6	15	32	55	0.761	-0.118	3.724	0.013	0.01	0	42.1	34	52.5	132	113	0	34	34	34
2025	4	6	15	42	55	0.751	-0.105	3.724	0.013	0.01	0	42.6	35.3	46	133	114	0	34	32	34
2025	4	6	15	52	55	0.761	-0.082	3.724	0.016	0.013	0	41.7	34.4	59.8	132	113	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	6	16	2	55	0.774	-0.079	3.72	0.01	0.007	0	41.7	34	48.2	132	113	0	35	34	34
2025	4	6	16	12	55	0.801	-0.089	3.72	0.016	0.013	0	42.1	34.4	47.7	132	113	0	34	33	34
2025	4	6	16	22	55	0.745	-0.069	3.72	0.013	0.01	0	41.3	34	47.7	131	112	0	35	33	34
2025	4	6	16	32	55	0.774	-0.085	3.72	0.013	0.01	0	40.9	33.1	68.4	130	111	0	35	34	34
2025	4	6	16	42	55	0.774	-0.085	3.72	0.01	0.007	0	42.1	34.4	58	132	113	0	34	33	33
2025	4	6	16	52	55	0.781	-0.135	3.72	0.01	0.007	0	40.9	33.5	74	130	111	0	35	33	34
2025	4	6	17	2	55	0.745	-0.112	3.72	0.01	0.007	0	40.9	33.1	73.5	130	111	0	35	34	34
2025	4	6	17	12	55	0.787	-0.092	3.72	0.01	0.007	0	41.3	33.5	73.5	130	111	0	34	33	34
2025	4	6	17	22	55	0.787	-0.098	3.717	0.01	0.007	0	40.9	33.5	72.7	130	111	0	35	33	34
2025	4	6	17	32	55	0.771	-0.082	3.714	0.01	0.007	0	41.3	34	72.2	131	112	0	35	33	34
2025	4	6	17	42	55	0.741	-0.085	3.714	0.016	0.013	0	41.7	33.1	73.1	131	111	0	34	34	34
2025	4	6	17	52	55	0.768	-0.095	3.707	0.016	0.013	0	41.3	34	73.1	131	112	0	35	33	33
2025	4	6	18	2	55	0.784	-0.089	3.704	0.01	0.007	0	41.3	34	72.7	131	112	0	35	33	34
2025	4	6	18	12	55	0.797	-0.108	3.704	0.013	0.01	0	41.3	34	72.7	131	112	0	35	33	34
2025	4	6	18	22	55	0.732	-0.082	3.704	0.01	0.007	0	41.7	33.5	73.1	131	112	0	34	34	34
2025	4	6	18	32	55	0.791	-0.085	3.701	0.01	0.007	0	42.1	34.4	74	132	113	0	34	33	34
2025	4	6	18	42	55	0.741	-0.108	3.701	0.01	0.007	0	42.1	34	73.5	132	113	0	34	34	34
2025	4	6	18	52	55	0.801	-0.085	3.701	0.013	0.01	0	42.6	34.8	74.4	133	114	0	34	33	33
2025	4	6	19	2	55	0.797	-0.121	3.698	0.013	0.01	0	43	35.3	74	134	115	0	34	33	34
2025	4	6	19	12	55	0.801	-0.095	3.698	0.01	0.007	0	42.6	35.3	74	134	115	0	35	33	34
2025	4	6	19	22	55	0.748	-0.125	3.698	0.013	0.01	0	43	36.1	74.4	135	117	0	35	33	34
2025	4	6	19	32	55	0.781	-0.085	3.698	0.016	0.013	0	44.3	35.7	73.5	136	117	0	33	34	34
2025	4	6	19	42	55	0.764	-0.102	3.698	0.013	0.01	0	43.4	35.7	74	136	117	0	35	34	34
2025	4	6	19	52	55	0.751	-0.085	3.694	0.013	0.01	0	43.4	35.7	74.4	136	117	0	35	34	34
2025	4	6	20	2	55	0.771	-0.112	3.694	0.013	0.01	0	43.9	35.7	71	136	117	0	34	34	34
2025	4	6	20	12	55	0.741	-0.098	3.694	0.01	0.007	0	43.4	36.5	74.4	136	118	0	35	33	35
2025	4	6	20	22	55	0.778	-0.108	3.691	0.013	0.01	0	43.4	35.7	74.8	136	117	0	35	34	34
2025	4	6	20	32	55	0.748	-0.125	3.691	0.01	0.007	0	44.3	36.5	74.4	137	118	0	34	33	34
2025	4	6	20	42	55	0.794	-0.069	3.691	0.01	0.007	0	43.9	36.1	74.8	137	118	0	35	34	34
2025	4	6	20	52	55	0.771	-0.072	3.688	0.01	0.007	0	44.7	36.5	74.4	138	119	0	34	34	34
2025	4	6	21	2	55	0.761	-0.115	3.688	0.01	0.007	0	43.9	36.5	74.8	137	118	0	35	33	34
2025	4	6	21	12	55	0.781	-0.072	3.688	0.013	0.01	0	44.7	37	74.4	138	119	0	34	33	35
2025	4	6	21	22	55	0.725	-0.115	3.688	0.01	0.007	0	44.3	36.5	74.8	138	119	0	35	34	35
2025	4	6	21	32	55	0.745	-0.089	3.684	0.02	0.016	0	44.3	36.5	75.7	138	119	0	35	34	34
2025	4	6	21	42	55	0.745	-0.085	3.684	0.01	0.007	0	44.7	37	75.7	138	120	0	34	34	34
2025	4	6	21	52	55	0.751	-0.059	3.684	0.013	0.01	0	44.3	36.5	75.7	138	119	0	35	34	35
2025	4	6	22	2	55	0.745	-0.069	3.684	0.013	0.01	0	43.9	36.1	76.1	137	118	0	35	34	34
2025	4	6	22	12	55	0.774	-0.092	3.681	0.01	0.007	0	43.9	36.1	76.1	137	118	0	35	34	34
2025	4	6	22	22	55	0.735	-0.115	3.681	0.01	0.007	0	43.9	36.1	75.7	137	118	0	35	34	35
2025	4	6	22	32	55	0.732	-0.098	3.681	0.016	0.013	0	43.9	36.1	76.1	137	118	0	35	34	34
2025	4	6	22	42	55	0.804	-0.102	3.681	0.016	0.013	0	43.9	36.5	76.5	138	119	0	36	34	34
2025	4	6	22	52	55	0.741	-0.098	3.678	0.016	0.013	0	44.7	36.5	75.7	138	119	0	34	34	35
2025	4	6	23	2	55	0.741	-0.085	3.678	0.01	0.007	0	44.3	37	76.1	138	119	0	35	33	34
2025	4	6	23	12	55	0.725	-0.075	3.678	0.013	0.01	0	44.3	37	76.1	138	119	0	35	33	34
2025	4	6	23	22	55	0.758	-0.072	3.678	0.013	0.01	0	44.7	36.5	76.1	138	119	0	34	34	34
2025	4	6	23	32	55	0.771	-0.089	3.675	0.01	0.007	0	44.7	36.5	76.5	138	119	0	34	34	34
2025	4	6	23	42	55	0.709	-0.115	3.675	0.01	0.007	0	43.9	36.5	76.5	137	119	0	35	34	35
2025	4	6	23	52	55	0.801	-0.089	3.675	0.016	0.016	0	44.7	36.5	77	139	119	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	7	0	2	55	0.771	-0.075	3.675	0.016	0.013	0	44.7	36.5	77.4	138	119	0	34	34	34
2025	4	7	0	12	55	0.758	-0.095	3.675	0.013	0.01	0	44.7	37	77.4	139	120	0	35	34	34
2025	4	7	0	22	55	0.741	-0.059	3.675	0.016	0.013	0	44.7	37.4	76.5	139	120	0	35	33	35
2025	4	7	0	32	55	0.764	-0.095	3.671	0.01	0.007	0	44.3	37	77.4	138	119	0	35	33	34
2025	4	7	0	42	55	0.735	-0.085	3.671	0.01	0.007	0	45.2	37.4	76.5	140	121	0	35	34	34
2025	4	7	0	52	55	0.791	-0.128	3.671	0.013	0.01	0	44.7	36.5	77	138	119	0	34	34	35
2025	4	7	1	2	55	0.709	-0.079	3.671	0.016	0.013	0	44.7	37	77.4	139	120	0	35	34	34
2025	4	7	1	12	55	0.791	-0.082	3.671	0.013	0.01	0	44.7	37	77	139	120	0	35	34	34
2025	4	7	1	22	55	0.764	-0.075	3.668	0.016	0.013	0	44.7	37.4	76.1	139	120	0	35	33	35
2025	4	7	1	32	55	0.738	-0.075	3.668	0.01	0.007	0	44.3	37	76.1	138	120	0	35	34	34
2025	4	7	1	42	55	0.761	-0.102	3.668	0.01	0.007	0	44.3	37	76.1	138	119	0	35	33	35
2025	4	7	1	52	55	0.758	-0.095	3.668	0.01	0.007	0	44.3	36.5	76.1	138	119	0	35	34	34
2025	4	7	2	2	55	0.751	-0.089	3.665	0.013	0.01	0	44.7	37	75.7	138	120	0	34	34	34
2025	4	7	2	12	55	0.719	-0.108	3.665	0.013	0.01	0	44.3	36.5	74.8	138	119	0	35	34	34
2025	4	7	2	22	55	0.728	-0.098	3.665	0.01	0.007	0	44.3	36.5	74.4	138	119	0	35	34	34
2025	4	7	2	32	55	0.771	-0.102	3.665	0.016	0.013	0	44.3	37	74	138	120	0	35	34	35
2025	4	7	2	42	55	0.751	-0.085	3.661	0.01	0.007	0	44.7	37.4	72.2	138	120	0	34	33	34
2025	4	7	2	52	55	0.748	-0.079	3.661	0.013	0.01	0	44.3	37	71.8	138	120	0	35	34	34
2025	4	7	3	2	55	0.764	-0.082	3.661	0.01	0.007	0	44.7	37	71.8	139	120	0	35	34	34
2025	4	7	3	12	55	0.745	-0.092	3.658	0.013	0.01	0	44.7	37.4	71.4	139	120	0	35	33	35
2025	4	7	3	22	55	0.751	-0.079	3.655	0.01	0.007	0	45.2	37.4	71.4	140	121	0	35	34	34
2025	4	7	3	32	55	0.722	-0.125	3.652	0.016	0.013	0	45.2	37.8	71	140	121	0	35	33	34
2025	4	7	3	42	55	0.758	-0.115	3.648	0.01	0.007	0	45.2	38.3	71	140	122	0	35	33	34
2025	4	7	3	52	55	0.725	-0.075	3.648	0.013	0.01	0	45.2	37.4	71.8	140	121	0	35	34	34
2025	4	7	4	2	55	0.768	-0.089	3.645	0.01	0.007	0	45.6	37.8	71.4	140	121	0	34	33	35
2025	4	7	4	12	55	0.751	-0.082	3.645	0.013	0.01	0	45.2	37.8	72.2	140	121	0	35	33	34
2025	4	7	4	22	55	0.761	-0.102	3.645	0.013	0.01	0	44.7	37	73.1	139	120	0	35	34	34
2025	4	7	4	32	55	0.745	-0.066	3.645	0.016	0.016	0	44.3	37.8	72.7	139	121	0	36	33	35
2025	4	7	4	42	55	0.728	-0.056	3.642	0.01	0.007	0	44.7	37.4	71.8	139	121	0	35	34	34
2025	4	7	4	52	55	0.748	-0.085	3.642	0.013	0.01	0	44.7	37.8	72.7	139	121	0	35	33	35
2025	4	7	5	2	55	0.755	-0.066	3.642	0.013	0.01	0	44.7	37.4	71.4	139	121	0	35	34	35
2025	4	7	5	12	55	0.722	-0.079	3.642	0.01	0.007	0	44.7	37	72.7	139	120	0	35	34	35
2025	4	7	5	22	55	0.696	-0.102	3.642	0.01	0.007	0	44.3	37.4	73.5	138	120	0	35	33	35
2025	4	7	5	32	55	0.709	-0.098	3.642	0.013	0.01	0	44.7	35.3	74.8	138	116	0	34	34	34
2025	4	7	5	42	55	0.735	-0.098	3.638	0.01	0.007	0	44.7	37.4	74.4	139	121	0	35	34	35
2025	4	7	5	52	55	0.738	-0.069	3.638	0.01	0.007	0	44.3	37	74.8	138	120	0	35	34	35
2025	4	7	6	2	55	0.755	-0.066	3.638	0.016	0.013	0	43.9	37	74.4	137	120	0	35	34	35
2025	4	7	6	12	55	0.719	-0.072	3.638	0.016	0.013	0	43.4	36.5	74.8	136	118	0	35	33	35
2025	4	7	6	22	55	0.722	-0.085	3.638	0.013	0.01	0	43.4	36.1	76.1	136	118	0	35	34	34
2025	4	7	6	32	55	0.741	-0.085	3.638	0.013	0.01	0	43	35.7	75.3	135	117	0	35	34	35
2025	4	7	6	42	55	0.735	-0.102	3.638	0.016	0.013	0	42.6	36.5	73.1	133	118	0	34	33	34
2025	4	7	6	52	55	0.705	-0.095	3.638	0.01	0.007	0	43	36.1	76.1	135	118	0	35	34	34
2025	4	7	7	2	55	0.741	-0.089	3.635	0.013	0.01	0	43	36.5	76.1	135	118	0	35	33	34
2025	4	7	7	12	55	0.709	-0.085	3.635	0.016	0.013	0	43	36.1	75.3	135	117	0	35	33	35
2025	4	7	7	22	55	0.745	-0.102	3.635	0.016	0.013	0	42.6	35.7	75.7	134	117	0	35	34	35
2025	4	7	7	32	55	0.728	-0.095	3.635	0.01	0.007	0	43.9	36.5	76.1	136	119	0	34	34	34
2025	4	7	7	42	55	0.728	-0.072	3.635	0.016	0.013	0	42.6	36.5	76.5	135	118	0	36	33	34
2025	4	7	7	52	55	0.728	-0.092	3.635	0.016	0.013	0	42.6	36.1	76.5	134	117	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	7	8	2	55	0.761	-0.098	3.635	0.01	0.007	0	43	36.1	75.3	135	118	0	35	34	35
2025	4	7	8	12	55	0.751	-0.066	3.635	0.013	0.01	0	43.4	37	74.4	136	120	0	35	34	35
2025	4	7	8	22	55	0.732	-0.089	3.632	0.01	0.007	0	43.9	37	73.5	137	120	0	35	34	34
2025	4	7	8	32	55	0.751	-0.092	3.632	0.01	0.007	0	43	36.5	73.5	135	118	0	35	33	35
2025	4	7	8	42	55	0.745	-0.112	3.632	0.01	0.007	0	42.6	36.5	73.1	134	118	0	35	33	34
2025	4	7	8	52	55	0.699	-0.115	3.629	0.016	0.013	0	43.4	36.5	70.5	136	119	0	35	34	34
2025	4	7	9	2	55	0.722	-0.089	3.625	0.013	0.01	0	43	36.5	67.1	135	119	0	35	34	34
2025	4	7	9	12	55	0.722	-0.095	3.619	0.016	0.013	0	43.9	36.5	56.8	136	119	0	34	34	34
2025	4	7	9	22	55	0.745	-0.125	3.619	0.013	0.01	0	43.4	37	60.6	136	120	0	35	34	34
2025	4	7	9	32	55	0.712	-0.105	3.615	0.01	0.007	0	43.4	36.5	56.3	136	119	0	35	34	34
2025	4	7	9	42	55	0.722	-0.095	3.615	0.02	0.016	0	43.4	37	57.6	136	119	0	35	33	35
2025	4	7	9	52	55	0.735	-0.072	3.615	0.01	0.007	0	43	36.1	70.1	135	118	0	35	34	34
2025	4	7	10	2	55	0.764	-0.098	3.615	0.013	0.01	0	43	37	70.5	135	119	0	35	33	34
2025	4	7	10	12	55	0.738	-0.095	3.612	0.016	0.013	0	43	36.1	67.9	134	118	0	34	34	34
2025	4	7	10	22	55	0.732	-0.098	3.612	0.01	0.007	0	43	37	67.9	135	119	0	35	33	34
2025	4	7	10	32	55	0.735	-0.098	3.612	0.013	0.01	0	42.1	35.7	72.7	133	117	0	35	34	34
2025	4	7	10	42	55	0.709	-0.082	3.612	0.01	0.007	0	42.6	36.1	63.2	134	118	0	35	34	34
2025	4	7	10	52	55	0.722	-0.089	3.612	0.013	0.01	0	42.6	36.5	67.1	134	118	0	35	33	34
2025	4	7	11	2	55	0.696	-0.072	3.612	0.01	0.007	0	42.6	36.1	51.2	134	118	0	35	34	35
2025	4	7	11	12	55	0.692	-0.069	3.612	0.01	0.007	0	43.9	37	49.5	136	119	0	34	33	35
2025	4	7	11	22	55	0.696	-0.082	3.612	0.016	0.013	0	43	36.5	50.7	135	118	0	35	33	34
2025	4	7	11	32	55	0.748	-0.098	3.615	0.013	0.01	0	43	36.1	47.7	134	117	0	34	33	34
2025	4	7	11	42	55	0.692	-0.072	3.612	0.01	0.007	0	41.7	35.7	50.7	132	116	0	35	33	34
2025	4	7	11	52	55	0.692	-0.085	3.612	0.01	0.007	0	42.1	35.7	48.6	133	117	0	35	34	35
2025	4	7	12	2	55	0.715	-0.108	3.612	0.01	0.007	0	42.6	36.1	49	133	117	0	34	33	34
2025	4	7	12	12	55	0.741	-0.089	3.612	0.01	0.007	0	42.6	36.5	45.6	134	118	0	35	33	34
2025	4	7	12	22	55	0.696	-0.082	3.609	0.013	0.01	0	42.6	36.5	46.9	134	118	0	35	33	34
2025	4	7	12	32	55	0.689	-0.089	3.609	0.01	0.007	0	42.6	36.1	48.2	134	117	0	35	33	34
2025	4	7	12	42	55	0.702	-0.098	3.609	0.016	0.013	0	43	36.1	49.9	134	117	0	34	33	34
2025	4	7	12	52	55	0.722	-0.043	3.609	0.016	0.013	0	42.6	36.5	51.2	134	118	0	35	33	34
2025	4	7	13	2	55	0.732	-0.089	3.609	0.01	0.007	0	43.4	37.4	46.9	135	119	0	34	32	35
2025	4	7	13	12	55	0.686	-0.075	3.609	0.01	0.007	0	43	36.5	49.5	135	118	0	35	33	33
2025	4	7	13	22	55	0.699	-0.085	3.606	0.013	0.01	0	42.6	37	47.7	134	118	0	35	32	34
2025	4	7	13	32	55	0.722	-0.102	3.606	0.01	0.007	0	43.4	36.1	46.9	135	118	0	34	34	34
2025	4	7	13	42	55	0.738	-0.125	3.606	0.016	0.013	0	43	37	46.4	135	119	0	35	33	34
2025	4	7	13	52	55	0.709	-0.069	3.606	0.013	0.01	0	43.4	36.5	47.7	135	118	0	34	33	34
2025	4	7	14	2	55	0.722	-0.089	3.606	0.016	0.013	0	42.1	36.1	48.6	133	117	0	35	33	34
2025	4	7	14	12	55	0.732	-0.052	3.606	0.016	0.013	0	42.6	36.1	47.7	133	117	0	34	33	34
2025	4	7	14	22	55	0.712	-0.075	3.606	0.016	0.016	0	42.1	36.1	49.9	133	117	0	35	33	34
2025	4	7	14	32	55	0.689	-0.118	3.606	0.01	0.007	0	43	36.5	47.3	134	118	0	34	33	33
2025	4	7	14	42	55	0.692	-0.085	3.602	0.01	0.007	0	43	36.1	55	134	117	0	34	33	34
2025	4	7	14	52	55	0.705	-0.095	3.602	0.01	0.007	0	43	36.1	54.2	134	117	0	34	33	33
2025	4	7	15	2	55	0.709	-0.089	3.599	0.01	0.007	0	42.1	36.1	58.9	133	117	0	35	33	34
2025	4	7	15	12	55	0.738	-0.112	3.599	0.01	0.007	0	42.6	36.1	52	133	117	0	34	33	34
2025	4	7	15	22	55	0.735	-0.135	3.596	0.01	0.007	0	42.6	36.1	55.5	134	117	0	35	33	34
2025	4	7	15	32	55	0.715	-0.105	3.599	0.01	0.007	0	42.6	36.1	50.7	134	117	0	35	33	35
2025	4	7	15	42	55	0.709	-0.069	3.599	0.013	0.01	0	42.6	36.5	53.3	134	118	0	35	33	34
2025	4	7	15	52	55	0.751	-0.121	3.596	0.013	0.01	0	42.1	36.1	73.5	133	117	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	7	16	2	55	0.728	-0.089	3.596	0.016	0.013	0	42.1	36.1	68.8	133	117	0	35	33	34
2025	4	7	16	12	55	0.656	-0.079	3.596	0.013	0.01	0	43	35.7	53.3	134	117	0	34	34	34
2025	4	7	16	22	55	0.738	-0.102	3.596	0.01	0.007	0	42.6	35.7	73.1	133	116	0	34	33	34
2025	4	7	16	32	55	0.719	-0.089	3.596	0.016	0.013	0	42.6	36.1	74.4	133	117	0	34	33	34
2025	4	7	16	42	55	0.725	-0.089	3.596	0.01	0.007	0	42.6	35.7	73.1	133	117	0	34	34	34
2025	4	7	16	52	55	0.738	-0.095	3.593	0.013	0.01	0	41.7	34.8	74.4	131	115	0	34	34	34
2025	4	7	17	2	55	0.738	-0.079	3.593	0.01	0.007	0	41.7	35.3	74.8	131	114	0	34	32	33
2025	4	7	17	12	55	0.702	-0.108	3.593	0.013	0.01	0	41.7	34.8	74.4	131	114	0	34	33	34
2025	4	7	17	22	55	0.728	-0.098	3.593	0.016	0.013	0	41.7	35.3	74.8	131	114	0	34	32	34
2025	4	7	17	32	55	0.722	-0.105	3.593	0.013	0.01	0	42.1	35.3	75.7	132	115	0	34	33	33
2025	4	7	17	42	55	0.738	-0.075	3.593	0.016	0.013	0	42.1	35.3	74.8	132	115	0	34	33	34
2025	4	7	17	52	55	0.738	-0.066	3.593	0.01	0.007	0	41.7	35.3	71.4	132	115	0	35	33	34
2025	4	7	18	2	55	0.755	-0.075	3.593	0.013	0.01	0	42.1	35.3	74.8	132	115	0	34	33	34
2025	4	7	18	12	55	0.689	-0.102	3.593	0.01	0.007	0	42.1	35.7	75.3	133	116	0	35	33	34
2025	4	7	18	22	55	0.705	-0.075	3.593	0.01	0.007	0	43	36.5	75.3	134	117	0	34	32	34
2025	4	7	18	32	55	0.702	-0.098	3.593	0.013	0.01	0	43.9	36.5	75.3	135	118	0	33	33	34
2025	4	7	18	42	55	0.722	-0.092	3.593	0.01	0.007	0	43.4	36.1	74.8	135	118	0	34	34	34
2025	4	7	18	52	55	0.758	-0.105	3.589	0.013	0.01	0	44.3	37.4	74.8	137	120	0	34	33	34
2025	4	7	19	2	55	0.771	-0.108	3.589	0.01	0.007	0	44.3	37.4	74.4	138	120	0	35	33	34
2025	4	7	19	12	55	0.722	-0.089	3.589	0.013	0.01	0	44.3	37.8	74	138	121	0	35	33	35
2025	4	7	19	22	55	0.692	-0.075	3.589	0.016	0.013	0	44.7	37.4	74.8	138	121	0	34	34	33
2025	4	7	19	32	55	0.761	-0.108	3.589	0.01	0.007	0	44.3	37.4	74	138	120	0	35	33	34
2025	4	7	19	42	55	0.741	-0.036	3.589	0.016	0.013	0	44.7	37.8	74.8	138	121	0	34	33	34
2025	4	7	19	52	55	0.741	-0.089	3.589	0.01	0.007	0	44.7	38.3	74	139	122	0	35	33	34
2025	4	7	20	2	55	0.699	-0.079	3.589	0.01	0.007	0	45.6	38.7	74.8	140	123	0	34	33	33
2025	4	7	20	12	55	0.705	-0.108	3.589	0.013	0.01	0	45.2	39.1	74.8	140	124	0	35	33	34
2025	4	7	20	22	55	0.696	-0.075	3.589	0.013	0.01	0	45.6	38.7	74.4	140	124	0	34	34	34
2025	4	7	20	32	55	0.692	-0.089	3.586	0.016	0.013	0	45.6	38.7	74.4	140	123	0	34	33	34
2025	4	7	20	42	55	0.745	-0.121	3.586	0.016	0.016	0	45.2	38.7	74.4	140	124	0	35	34	34
2025	4	7	20	52	55	0.702	-0.072	3.586	0.013	0.01	0	44.7	38.7	74.8	139	123	0	35	33	34
2025	4	7	21	2	55	0.732	-0.095	3.586	0.013	0.01	0	45.2	38.7	74	139	123	0	34	33	34
2025	4	7	21	12	55	0.686	-0.089	3.586	0.013	0.01	0	44.7	38.3	74.8	139	123	0	35	34	34
2025	4	7	21	22	55	0.725	-0.089	3.586	0.013	0.01	0	45.6	38.3	74.4	140	123	0	34	34	34
2025	4	7	21	32	55	0.764	-0.098	3.586	0.01	0.007	0	45.2	38.7	73.5	140	123	0	35	33	34
2025	4	7	21	42	55	0.686	-0.072	3.586	0.01	0.007	0	45.2	38.7	74	140	124	0	35	34	34
2025	4	7	21	52	55	0.725	-0.105	3.586	0.016	0.013	0	44.7	38.7	74.4	138	123	0	34	33	34
2025	4	7	22	2	55	0.722	-0.092	3.586	0.013	0.01	0	44.7	38.7	74	139	123	0	35	33	34
2025	4	7	22	12	55	0.741	-0.102	3.583	0.013	0.01	0	44.7	38.7	71.8	139	123	0	35	33	34
2025	4	7	22	22	55	0.728	-0.072	3.586	0.01	0.007	0	44.7	38.7	73.5	139	123	0	35	33	34
2025	4	7	22	32	55	0.728	-0.105	3.586	0.013	0.01	0	45.2	39.1	73.1	140	124	0	35	33	34
2025	4	7	22	42	55	0.719	-0.089	3.586	0.01	0.007	0	44.7	38.7	73.5	139	123	0	35	33	34
2025	4	7	22	52	55	0.751	-0.062	3.586	0.013	0.01	0	45.2	38.3	73.1	139	123	0	34	34	34
2025	4	7	23	2	55	0.741	-0.075	3.586	0.01	0.007	0	44.7	38.7	73.1	139	123	0	35	33	34
2025	4	7	23	12	55	0.738	-0.085	3.583	0.01	0.007	0	45.2	38.3	72.2	139	123	0	34	34	35
2025	4	7	23	22	55	0.738	-0.072	3.583	0.01	0.007	0	44.3	37.8	72.7	138	122	0	35	34	34
2025	4	7	23	32	55	0.728	-0.069	3.583	0.016	0.013	0	45.2	38.3	72.7	139	122	0	34	33	34
2025	4	7	23	42	55	0.712	-0.052	3.583	0.013	0.01	0	44.3	38.3	71.8	138	122	0	35	33	34
2025	4	7	23	52	55	0.725	-0.092	3.583	0.01	0.007	0	44.7	38.3	71.8	138	123	0	34	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	8	0	2	55	0.745	-0.072	3.583	0.01	0.007	0	44.3	38.3	70.5	138	123	0	35	34	35
2025	4	8	0	12	55	0.722	-0.089	3.583	0.016	0.013	0	44.3	38.7	71.8	138	123	0	35	33	34
2025	4	8	0	22	55	0.699	-0.092	3.583	0.01	0.007	0	44.7	38.7	71.4	139	123	0	35	33	34
2025	4	8	0	32	55	0.696	-0.069	3.583	0.016	0.013	0	44.7	38.7	71.4	138	123	0	34	33	34
2025	4	8	0	42	55	0.741	-0.118	3.583	0.013	0.01	0	44.3	37.8	70.5	138	122	0	35	34	34
2025	4	8	0	52	55	0.705	-0.082	3.583	0.013	0.01	0	44.3	37.8	71.8	138	122	0	35	34	34
2025	4	8	1	2	55	0.679	-0.072	3.583	0.016	0.013	0	45.2	38.3	71.4	139	123	0	34	34	34
2025	4	8	1	12	55	0.702	-0.089	3.583	0.013	0.01	0	44.3	37.8	71.4	138	122	0	35	34	34
2025	4	8	1	22	55	0.715	-0.072	3.583	0.013	0.01	0	45.2	38.3	71.4	139	123	0	34	34	34
2025	4	8	1	32	55	0.751	-0.108	3.583	0.013	0.01	0	44.3	38.3	71.4	138	122	0	35	33	34
2025	4	8	1	42	55	0.719	-0.092	3.583	0.01	0.007	0	44.3	38.3	71.8	138	122	0	35	33	34
2025	4	8	1	52	55	0.719	-0.102	3.583	0.013	0.01	0	44.7	37.8	71	138	122	0	34	34	35
2025	4	8	2	2	55	0.709	-0.125	3.583	0.01	0.007	0	44.7	38.3	71	138	122	0	34	33	34
2025	4	8	2	12	55	0.702	-0.131	3.583	0.013	0.01	0	44.3	37.8	70.5	138	122	0	35	34	35
2025	4	8	2	22	55	0.725	-0.066	3.583	0.016	0.013	0	44.7	38.7	71	139	123	0	35	33	34
2025	4	8	2	32	55	0.732	-0.112	3.583	0.013	0.01	0	44.3	38.3	71	138	123	0	35	34	35
2025	4	8	2	42	55	0.702	-0.059	3.583	0.013	0.01	0	44.7	38.3	71	139	123	0	35	34	34
2025	4	8	2	52	55	0.712	-0.095	3.583	0.013	0.01	0	44.7	38.3	70.5	139	123	0	35	34	35
2025	4	8	3	2	55	0.725	-0.098	3.579	0.013	0.01	0	44.7	38.7	70.5	138	123	0	34	33	35
2025	4	8	3	12	55	0.732	-0.079	3.579	0.013	0.01	0	44.3	38.7	71.4	138	123	0	35	33	34
2025	4	8	3	22	55	0.745	-0.072	3.579	0.01	0.007	0	44.7	38.3	70.5	139	123	0	35	34	35
2025	4	8	3	32	55	0.738	-0.069	3.579	0.01	0.007	0	44.7	38.3	71.4	139	123	0	35	34	34
2025	4	8	3	42	55	0.728	-0.112	3.579	0.01	0.007	0	45.2	38.7	71.4	139	123	0	34	33	34
2025	4	8	3	52	55	0.719	-0.102	3.579	0.016	0.016	0	44.7	38.7	70.5	139	124	0	35	34	35
2025	4	8	4	2	55	0.715	-0.089	3.579	0.01	0.007	0	45.2	38.3	71.4	139	123	0	34	34	34
2025	4	8	4	12	55	0.715	-0.125	3.579	0.013	0.01	0	44.7	38.7	71.4	139	124	0	35	34	34
2025	4	8	4	22	55	0.761	-0.128	3.579	0.01	0.007	0	44.3	38.3	71.8	138	123	0	35	34	34
2025	4	8	4	32	55	0.745	-0.069	3.576	0.016	0.013	0	44.7	38.3	72.2	139	123	0	35	34	34
2025	4	8	4	42	55	0.709	-0.092	3.576	0.01	0.007	0	44.7	38.7	67.9	139	123	0	35	33	34
2025	4	8	4	52	55	0.705	-0.069	3.576	0.016	0.013	0	44.3	38.7	72.2	138	123	0	35	33	34
2025	4	8	5	2	55	0.719	-0.082	3.576	0.013	0.01	0	44.3	38.7	72.7	138	123	0	35	33	34
2025	4	8	5	12	55	0.784	-0.075	3.576	0.013	0.01	0	43.9	37.8	73.1	137	121	0	35	33	34
2025	4	8	5	22	55	0.719	-0.079	3.576	0.01	0.007	0	44.3	38.3	73.1	138	122	0	35	33	34
2025	4	8	5	32	55	0.692	-0.118	3.576	0.01	0.007	0	43.9	37.8	73.5	137	121	0	35	33	34
2025	4	8	5	42	55	0.732	-0.092	3.573	0.013	0.01	0	45.2	37.4	72.7	140	120	0	35	33	34
2025	4	8	5	52	55	0.732	-0.105	3.573	0.013	0.01	0	44.7	37.4	72.7	139	121	0	35	34	34
2025	4	8	6	2	55	0.761	-0.102	3.573	0.016	0.013	0	44.7	37.4	73.5	139	120	0	35	33	34
2025	4	8	6	12	55	0.719	-0.108	3.573	0.016	0.013	0	45.2	37	72.7	139	120	0	34	34	34
2025	4	8	6	22	55	0.719	-0.066	3.573	0.01	0.007	0	44.3	37	74.4	138	119	0	35	33	34
2025	4	8	6	32	55	0.699	-0.082	3.573	0.013	0.01	0	43.9	36.5	74.8	137	118	0	35	33	34
2025	4	8	6	42	55	0.712	-0.085	3.573	0.013	0.01	0	43.4	35.3	74.8	135	116	0	34	34	34
2025	4	8	6	52	55	0.696	-0.102	3.573	0.01	0.007	0	43	35.7	74.4	135	116	0	35	33	34
2025	4	8	7	2	55	0.719	-0.066	3.573	0.01	0.007	0	43.4	35.7	74.4	136	117	0	35	34	35
2025	4	8	7	12	55	0.741	-0.098	3.573	0.013	0.01	0	43	35.3	75.3	134	115	0	34	33	34
2025	4	8	7	22	55	0.728	-0.072	3.573	0.01	0.007	0	43	35.3	75.3	135	116	0	35	34	34
2025	4	8	7	32	55	0.712	-0.095	3.57	0.013	0.01	0	42.6	34.8	74.8	133	114	0	34	33	34
2025	4	8	7	42	55	0.722	-0.102	3.573	0.013	0.01	0	42.6	34.4	75.7	133	114	0	34	34	34
2025	4	8	7	52	55	0.692	-0.085	3.57	0.01	0.007	0	43	35.7	75.3	135	116	0	35	33	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	8	8	2	55	0.725	-0.089	3.573	0.01	0.007	0	42.6	35.3	75.3	134	115	0	35	33	34
2025	4	8	8	12	55	0.692	-0.125	3.573	0.013	0.01	0	42.6	35.3	76.1	134	116	0	35	34	34
2025	4	8	8	22	55	0.728	-0.072	3.573	0.01	0.007	0	43.9	36.5	75.7	137	118	0	35	33	34
2025	4	8	8	32	55	0.712	-0.079	3.573	0.01	0.007	0	43.4	36.1	76.1	136	118	0	35	34	34
2025	4	8	8	42	55	0.728	-0.112	3.573	0.01	0.007	0	43.4	36.1	76.5	136	118	0	35	34	34
2025	4	8	8	52	55	0.738	-0.089	3.573	0.01	0.007	0	43.4	36.5	76.5	136	118	0	35	33	34
2025	4	8	9	2	55	0.741	-0.066	3.573	0.01	0.007	0	43.9	36.5	76.5	137	119	0	35	34	34
2025	4	8	9	12	55	0.732	-0.125	3.573	0.01	0.007	0	43.4	36.1	69.7	136	118	0	35	34	34
2025	4	8	9	22	55	0.712	-0.089	3.573	0.016	0.013	0	43.4	36.1	59.3	136	117	0	35	33	34
2025	4	8	9	32	55	0.719	-0.079	3.573	0.013	0.01	0	43.9	36.1	67.5	137	118	0	35	34	34
2025	4	8	9	42	55	0.709	-0.079	3.576	0.016	0.013	0	43.9	36.5	67.9	137	119	0	35	34	34
2025	4	8	9	52	55	0.709	-0.089	3.576	0.016	0.013	0	43.9	36.5	71	136	118	0	34	33	34
2025	4	8	10	2	55	0.699	-0.092	3.573	0.016	0.016	0	44.3	37	54.6	137	119	0	34	33	34
2025	4	8	10	12	55	0.728	-0.098	3.573	0.01	0.007	0	44.3	36.5	57.6	138	119	0	35	34	34
2025	4	8	10	22	55	0.735	-0.069	3.573	0.01	0.007	0	44.3	36.5	49.9	137	119	0	34	34	34
2025	4	8	10	32	55	0.705	-0.108	3.573	0.016	0.016	0	44.3	37	52.5	138	120	0	35	34	34
2025	4	8	10	42	55	0.738	-0.118	3.576	0.013	0.01	0	44.3	37.8	74	138	120	0	35	32	34
2025	4	8	10	52	55	0.728	-0.115	3.573	0.013	0.01	0	44.7	37.4	52.5	139	121	0	35	34	34
2025	4	8	11	2	55	0.735	-0.089	3.576	0.01	0.007	0	44.3	37.8	67.5	138	120	0	35	32	34
2025	4	8	11	12	55	0.719	-0.108	3.576	0.016	0.013	0	44.7	37.8	50.3	139	121	0	35	33	34
2025	4	8	11	22	55	0.692	-0.085	3.576	0.01	0.007	0	45.2	37.4	54.2	140	121	0	35	34	33
2025	4	8	11	32	55	0.728	-0.059	3.576	0.016	0.016	0	44.3	37	58	138	120	0	35	34	34
2025	4	8	11	42	55	0.725	-0.128	3.573	0.013	0.01	0	44.3	37	51.6	137	119	0	34	33	34
2025	4	8	11	52	55	0.722	-0.095	3.576	0.01	0.007	0	43.9	36.1	54.2	136	117	0	34	33	33
2025	4	8	12	2	55	0.696	-0.059	3.576	0.01	0.007	0	43.9	36.5	52.5	137	119	0	35	34	34
2025	4	8	12	12	55	0.702	-0.105	3.573	0.01	0.007	0	44.3	37	53.3	137	119	0	34	33	34
2025	4	8	12	22	55	0.696	-0.115	3.576	0.016	0.013	0	44.3	37	64.5	137	119	0	34	33	34
2025	4	8	12	32	55	0.699	-0.075	3.576	0.016	0.013	0	44.3	37.4	52.9	137	119	0	34	32	34
2025	4	8	12	42	55	0.715	-0.075	3.579	0.013	0.01	0	44.7	37.4	66.7	138	120	0	34	33	34
2025	4	8	12	52	55	0.702	-0.105	3.579	0.01	0.007	0	44.3	37	68.8	137	119	0	34	33	34
2025	4	8	13	2	55	0.722	-0.105	3.576	0.01	0.007	0	45.2	37.4	55	139	121	0	34	34	34
2025	4	8	13	12	55	0.719	-0.108	3.576	0.01	0.007	0	44.7	37.8	58.9	139	121	0	35	33	34
2025	4	8	13	22	55	0.728	-0.089	3.573	0.01	0.007	0	43.9	37	49.9	137	119	0	35	33	33
2025	4	8	13	32	55	0.699	-0.069	3.573	0.016	0.013	0	43.9	36.5	48.2	136	117	0	34	32	35
2025	4	8	13	42	55	0.722	-0.085	3.579	0.013	0.01	0	43.4	36.1	72.2	135	117	0	34	33	34
2025	4	8	13	52	55	0.751	-0.075	3.579	0.01	0.007	0	43	35.3	73.5	135	116	0	35	34	34
2025	4	8	14	2	55	0.741	-0.066	3.576	0.01	0.007	0	43.4	36.5	71.8	135	117	0	34	32	34
2025	4	8	14	12	55	0.725	-0.089	3.57	0.016	0.016	0	43.4	36.5	53.8	136	118	0	35	33	33
2025	4	8	14	22	55	0.715	-0.089	3.57	0.01	0.007	0	43.4	36.5	66.2	136	118	0	35	33	34
2025	4	8	14	32	55	0.715	-0.092	3.57	0.013	0.01	0	44.3	36.5	50.7	137	119	0	34	34	34
2025	4	8	14	42	55	0.728	-0.102	3.57	0.016	0.013	0	44.3	37.4	64.1	137	119	0	34	32	34
2025	4	8	14	52	55	0.751	-0.108	3.566	0.013	0.01	0	44.3	37	64.1	137	119	0	34	33	33
2025	4	8	15	2	55	0.705	-0.075	3.57	0.01	0.007	0	44.3	36.5	48.2	137	118	0	34	33	34
2025	4	8	15	12	55	0.738	-0.085	3.57	0.01	0.007	0	43.9	36.5	49	136	118	0	34	33	34
2025	4	8	15	22	55	0.761	-0.105	3.57	0.013	0.01	0	43.9	36.1	48.2	136	117	0	34	33	34
2025	4	8	15	32	55	0.689	-0.072	3.57	0.01	0.007	0	43.4	36.5	49.9	136	118	0	35	33	33
2025	4	8	15	42	55	0.696	-0.069	3.57	0.01	0.007	0	43.9	37	48.6	136	118	0	34	32	34
2025	4	8	15	52	55	0.722	-0.085	3.57	0.013	0.01	0	43.9	36.5	48.2	136	117	0	34	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	8	16	2	55	0.741	-0.089	3.57	0.013	0.01	0	43.4	35.7	50.3	135	116	0	34	33	34
2025	4	8	16	12	55	0.702	-0.105	3.566	0.013	0.01	0	43.4	35.7	51.2	135	116	0	34	33	34
2025	4	8	16	22	55	0.735	-0.082	3.57	0.016	0.013	0	43.9	36.5	47.3	136	118	0	34	33	34
2025	4	8	16	32	55	0.692	-0.098	3.566	0.013	0.01	0	43.9	36.5	54.6	136	118	0	34	33	33
2025	4	8	16	42	55	0.748	-0.069	3.566	0.01	0.007	0	43.9	36.1	51.6	136	117	0	34	33	33
2025	4	8	16	52	55	0.715	-0.092	3.566	0.01	0.007	0	44.3	36.1	52	137	117	0	34	33	33
2025	4	8	17	2	55	0.686	-0.095	3.566	0.013	0.01	0	44.7	36.1	61.1	137	117	0	33	33	34
2025	4	8	17	12	55	0.705	-0.128	3.566	0.013	0.01	0	44.3	36.5	55	137	117	0	34	32	34
2025	4	8	17	22	55	0.699	-0.105	3.566	0.01	0.007	0	44.3	37	70.5	137	118	0	34	32	34
2025	4	8	17	32	55	0.682	-0.056	3.566	0.016	0.016	0	44.7	37	71.4	138	118	0	34	32	34
2025	4	8	17	42	55	0.702	-0.079	3.566	0.013	0.01	0	43.9	36.1	73.5	137	117	0	35	33	33
2025	4	8	17	52	55	0.715	-0.082	3.566	0.013	0.01	0	44.3	35.7	73.1	137	116	0	34	33	33
2025	4	8	18	2	55	0.778	-0.095	3.566	0.01	0.007	0	43.9	36.1	73.1	137	117	0	35	33	34
2025	4	8	18	12	55	0.659	-0.085	3.566	0.013	0.01	0	44.3	36.1	73.5	138	117	0	35	33	33
2025	4	8	18	22	55	0.741	-0.072	3.566	0.01	0.007	0	44.7	36.1	72.2	138	117	0	34	33	34
2025	4	8	18	32	55	0.761	-0.089	3.566	0.01	0.007	0	45.2	37.4	72.7	139	119	0	34	32	33
2025	4	8	18	42	55	0.722	-0.062	3.566	0.013	0.01	0	46.4	38.3	72.2	141	121	0	33	32	34
2025	4	8	18	52	55	0.709	-0.066	3.566	0.013	0.01	0	45.6	37.8	71.8	141	121	0	35	33	34
2025	4	8	19	2	55	0.722	-0.118	3.566	0.013	0.01	0	46	37.8	71.8	141	121	0	34	33	34
2025	4	8	19	12	55	0.732	-0.098	3.566	0.013	0.01	0	46.4	37.8	71.8	142	121	0	34	33	34
2025	4	8	19	22	55	0.712	-0.043	3.566	0.01	0.007	0	46.9	38.3	71.8	143	122	0	34	33	33
2025	4	8	19	32	55	0.735	-0.072	3.566	0.013	0.01	0	46.9	39.1	71.4	143	123	0	34	32	33
2025	4	8	19	42	55	0.728	-0.069	3.566	0.013	0.01	0	46.9	39.1	71.4	143	124	0	34	33	34
2025	4	8	19	52	55	0.751	-0.102	3.566	0.01	0.007	0	46.9	39.1	71.8	143	123	0	34	32	34
2025	4	8	20	2	55	0.728	-0.105	3.563	0.016	0.013	0	46.4	39.1	71.4	142	123	0	34	32	34
2025	4	8	20	12	55	0.722	-0.062	3.566	0.013	0.01	0	46.9	39.6	71.8	144	124	0	35	32	33
2025	4	8	20	22	55	0.715	-0.102	3.566	0.016	0.013	0	46.9	38.7	71.8	143	123	0	34	33	34
2025	4	8	20	32	55	0.709	-0.092	3.566	0.013	0.01	0	46.9	39.1	71.4	143	124	0	34	33	34
2025	4	8	20	42	55	0.705	-0.135	3.566	0.01	0.007	0	46.9	39.1	71	143	124	0	34	33	34
2025	4	8	20	52	55	0.755	-0.121	3.563	0.016	0.013	0	46.9	39.1	71	143	124	0	34	33	34
2025	4	8	21	2	55	0.728	-0.072	3.566	0.013	0.01	0	46.9	38.7	71	143	124	0	34	34	34
2025	4	8	21	12	55	0.722	-0.079	3.566	0.013	0.01	0	46.4	38.7	71	142	123	0	34	33	34
2025	4	8	21	22	55	0.728	-0.056	3.566	0.013	0.01	0	46.9	38.7	70.5	143	124	0	34	34	34
2025	4	8	21	32	55	0.699	-0.092	3.566	0.013	0.01	0	46.9	39.1	70.5	143	124	0	34	33	34
2025	4	8	21	42	55	0.669	-0.098	3.57	0.013	0.01	0	46.9	39.1	71.8	143	124	0	34	33	33
2025	4	8	21	52	55	0.755	-0.102	3.573	0.013	0.01	0	46.9	39.1	71.8	143	124	0	34	33	34
2025	4	8	22	2	55	0.732	-0.079	3.573	0.013	0.01	0	46.4	38.7	72.2	143	123	0	35	33	34
2025	4	8	22	12	55	0.699	-0.089	3.573	0.013	0.01	0	46.9	39.1	71.4	143	124	0	34	33	34
2025	4	8	22	22	55	0.745	-0.098	3.573	0.016	0.016	0	46.4	39.1	71.4	143	124	0	35	33	34
2025	4	8	22	32	55	0.728	-0.102	3.573	0.013	0.01	0	46	39.1	71	142	124	0	35	33	34
2025	4	8	22	42	55	0.709	-0.059	3.573	0.016	0.013	0	46.9	39.1	71.4	143	124	0	34	33	34
2025	4	8	22	52	55	0.686	-0.098	3.573	0.01	0.007	0	46.9	38.7	72.2	144	123	0	35	33	34
2025	4	8	23	2	55	0.686	-0.089	3.573	0.013	0.01	0	46.4	38.7	72.2	142	123	0	34	33	34
2025	4	8	23	12	55	0.689	-0.079	3.573	0.013	0.01	0	46	38.7	71.8	142	123	0	35	33	34
2025	4	8	23	22	55	0.666	-0.079	3.573	0.016	0.013	0	46.9	38.7	73.1	143	123	0	34	33	34
2025	4	8	23	32	55	0.692	-0.075	3.573	0.013	0.01	0	46	38.3	72.7	142	122	0	35	33	34
2025	4	8	23	42	55	0.689	-0.072	3.573	0.013	0.01	0	46	38.3	73.5	142	122	0	35	33	34
2025	4	8	23	52	55	0.663	-0.115	3.573	0.013	0.01	0	46.4	38.3	74	142	122	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	9	0	2	55	0.682	-0.085	3.573	0.016	0.013	0	45.6	38.3	72.7	141	122	0	35	33	34
2025	4	9	0	12	55	0.705	-0.098	3.573	0.013	0.01	0	46	38.3	74.4	141	122	0	34	33	34
2025	4	9	0	22	55	0.692	-0.085	3.573	0.013	0.01	0	46.4	38.3	74	142	122	0	34	33	34
2025	4	9	0	32	55	0.699	-0.072	3.573	0.016	0.013	0	46.4	38.3	73.5	142	123	0	34	34	34
2025	4	9	0	42	55	0.682	-0.085	3.573	0.013	0.01	0	46	39.1	75.3	142	124	0	35	33	34
2025	4	9	0	52	55	0.712	-0.072	3.573	0.016	0.016	0	46.4	39.1	74.8	143	124	0	35	33	34
2025	4	9	1	2	55	0.715	-0.059	3.573	0.013	0.01	0	46.9	39.6	74.4	143	125	0	34	33	35
2025	4	9	1	12	55	0.738	-0.082	3.573	0.01	0.007	0	46.4	39.1	74	142	124	0	34	33	35
2025	4	9	1	22	55	0.715	-0.066	3.573	0.013	0.01	0	47.3	39.1	75.7	144	124	0	34	33	34
2025	4	9	1	32	55	0.715	-0.092	3.573	0.013	0.01	0	46.9	39.1	75.7	144	124	0	35	33	34
2025	4	9	1	42	55	0.686	-0.089	3.573	0.016	0.013	0	46.9	39.1	75.3	143	124	0	34	33	34
2025	4	9	1	52	55	0.722	-0.072	3.573	0.016	0.013	0	47.3	39.1	75.7	144	124	0	34	33	33
2025	4	9	2	2	55	0.679	-0.043	3.573	0.016	0.013	0	47.3	39.1	75.7	144	124	0	34	33	34
2025	4	9	2	12	55	0.725	-0.043	3.573	0.01	0.007	0	47.3	38.7	75.7	144	124	0	34	34	34
2025	4	9	2	22	55	0.738	-0.056	3.573	0.016	0.013	0	47.3	39.1	76.1	144	124	0	34	33	34
2025	4	9	2	32	55	0.732	-0.075	3.573	0.016	0.013	0	46.4	39.1	76.1	143	124	0	35	33	34
2025	4	9	2	42	55	0.699	-0.059	3.573	0.016	0.013	0	46.9	38.7	76.1	143	123	0	34	33	34
2025	4	9	2	52	55	0.715	-0.059	3.573	0.01	0.007	0	47.3	39.1	76.1	144	124	0	34	33	33
2025	4	9	3	2	55	0.699	-0.072	3.573	0.013	0.01	0	46.4	38.3	77	142	123	0	34	34	34
2025	4	9	3	12	55	0.699	-0.052	3.573	0.013	0.01	0	46.4	39.1	76.1	143	124	0	35	33	34
2025	4	9	3	22	55	0.705	-0.049	3.573	0.01	0.007	0	46	38.3	76.1	142	123	0	35	34	35
2025	4	9	3	32	55	0.699	-0.059	3.573	0.013	0.01	0	46.4	39.1	76.1	143	124	0	35	33	34
2025	4	9	3	42	55	0.682	-0.072	3.573	0.01	0.007	0	46.4	39.1	76.1	143	124	0	35	33	34
2025	4	9	3	52	55	0.728	-0.082	3.573	0.01	0.007	0	46.4	38.7	75.3	143	124	0	35	34	34
2025	4	9	4	2	55	0.699	-0.075	3.573	0.016	0.013	0	46.9	39.1	75.7	144	124	0	35	33	34
2025	4	9	4	12	55	0.728	-0.089	3.573	0.013	0.01	0	46.9	38.3	75.7	143	123	0	34	34	33
2025	4	9	4	22	55	0.715	-0.066	3.573	0.01	0.007	0	46	38.3	75.7	142	123	0	35	34	35
2025	4	9	4	32	55	0.705	-0.082	3.573	0.013	0.01	0	46	38.3	77	142	122	0	35	33	34
2025	4	9	4	42	55	0.709	-0.079	3.573	0.013	0.01	0	45.6	38.3	76.1	141	122	0	35	33	34
2025	4	9	4	52	55	0.755	-0.092	3.573	0.013	0.01	0	45.6	38.3	76.5	141	122	0	35	33	34
2025	4	9	5	2	55	0.728	-0.089	3.573	0.013	0.01	0	45.2	37.4	76.5	140	121	0	35	34	34
2025	4	9	5	12	55	0.705	-0.056	3.573	0.013	0.01	0	45.6	38.3	76.5	140	122	0	34	33	34
2025	4	9	5	22	55	0.732	-0.066	3.573	0.01	0.007	0	45.6	37.8	76.5	140	121	0	34	33	34
2025	4	9	5	32	55	0.758	-0.092	3.573	0.01	0.007	0	45.2	37.8	76.5	139	121	0	34	33	35
2025	4	9	5	42	55	0.761	-0.095	3.573	0.016	0.013	0	46	37.4	77	141	120	0	34	33	34
2025	4	9	5	52	55	0.709	-0.095	3.573	0.013	0.01	0	45.6	37.8	77.8	141	121	0	35	33	34
2025	4	9	6	2	55	0.741	-0.085	3.573	0.013	0.01	0	45.6	37.4	77	140	120	0	34	33	35
2025	4	9	6	12	55	0.692	-0.089	3.573	0.01	0.007	0	45.2	37.4	77.4	139	120	0	34	33	34
2025	4	9	6	22	55	0.715	-0.092	3.57	0.01	0.007	0	45.2	37.4	77.8	140	120	0	35	33	34
2025	4	9	6	32	55	0.735	-0.089	3.57	0.016	0.013	0	45.6	37	76.5	140	120	0	34	34	34
2025	4	9	6	42	55	0.679	-0.089	3.57	0.013	0.01	0	44.7	37	75.3	139	119	0	35	33	35
2025	4	9	6	52	55	0.689	-0.092	3.57	0.013	0.01	0	44.3	36.1	77	138	118	0	35	34	34
2025	4	9	7	2	55	0.722	-0.092	3.57	0.013	0.01	0	43.9	36.5	75.7	136	117	0	34	32	35
2025	4	9	7	12	55	0.758	-0.085	3.57	0.01	0.007	0	44.3	37	75.3	137	118	0	34	32	34
2025	4	9	7	22	55	0.745	-0.072	3.57	0.01	0.007	0	44.3	36.5	75.3	138	118	0	35	33	34
2025	4	9	7	32	55	0.741	-0.118	3.57	0.013	0.01	0	43.9	36.1	75.3	136	117	0	34	33	35
2025	4	9	7	42	55	0.745	-0.056	3.57	0.013	0.01	0	43.9	35.7	74.8	136	117	0	34	34	34
2025	4	9	7	52	55	0.774	-0.079	3.57	0.013	0.01	0	44.3	36.5	75.7	137	118	0	34	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	9	8	2	55	0.758	-0.069	3.57	0.016	0.016	0	44.3	37	74	138	119	0	35	33	34
2025	4	9	8	12	55	0.725	-0.095	3.57	0.013	0.01	0	43.9	36.5	74.4	136	118	0	34	33	34
2025	4	9	8	22	55	0.751	-0.102	3.566	0.013	0.01	0	43.9	36.5	73.5	136	118	0	34	33	34
2025	4	9	8	32	55	0.735	-0.112	3.566	0.016	0.013	0	43.9	37	73.5	136	118	0	34	32	34
2025	4	9	8	42	55	0.728	-0.108	3.566	0.016	0.013	0	43.4	36.1	74.4	136	117	0	35	33	34
2025	4	9	8	52	55	0.689	-0.128	3.563	0.01	0.007	0	43.9	37	74	137	119	0	35	33	35
2025	4	9	9	2	55	0.748	-0.089	3.563	0.01	0.007	0	43.9	36.1	74.8	137	118	0	35	34	33
2025	4	9	9	12	55	0.741	-0.085	3.56	0.016	0.013	0	43	36.1	74.4	135	117	0	35	33	35
2025	4	9	9	22	55	0.778	-0.075	3.56	0.013	0.01	0	43.9	36.1	74	136	117	0	34	33	34
2025	4	9	9	32	55	0.696	-0.105	3.56	0.01	0.007	0	44.7	36.5	74.8	138	119	0	34	34	33
2025	4	9	9	42	55	0.725	-0.082	3.56	0.013	0.01	0	44.3	35.3	75.3	137	116	0	34	34	34
2025	4	9	9	52	55	0.702	-0.089	3.56	0.016	0.013	0	44.3	35.7	75.3	137	116	0	34	33	34
2025	4	9	10	2	55	0.719	-0.072	3.56	0.013	0.01	0	44.3	35.7	75.7	137	116	0	34	33	34
2025	4	9	10	12	55	0.732	-0.062	3.56	0.016	0.013	0	44.7	36.5	74.8	138	118	0	34	33	34
2025	4	9	10	22	55	0.689	-0.069	3.56	0.013	0.01	0	44.7	36.5	75.7	138	118	0	34	33	34
2025	4	9	10	32	55	0.722	-0.118	3.56	0.01	0.007	0	44.3	36.1	76.1	138	117	0	35	33	34
2025	4	9	10	42	55	0.705	-0.095	3.563	0.016	0.013	0	44.7	36.5	76.1	138	118	0	34	33	34
2025	4	9	10	52	55	0.689	-0.059	3.56	0.01	0.007	0	43.9	36.1	76.1	136	117	0	34	33	34
2025	4	9	11	2	55	0.692	-0.072	3.56	0.01	0.007	0	43.9	36.1	76.1	137	117	0	35	33	34
2025	4	9	11	12	55	0.715	-0.108	3.56	0.016	0.016	0	43.9	35.7	76.1	136	116	0	34	33	34
2025	4	9	11	22	55	0.702	-0.102	3.56	0.013	0.01	0	43.4	35.7	76.1	135	116	0	34	33	34
2025	4	9	11	32	55	0.735	-0.056	3.563	0.01	0.007	0	43.9	35.3	76.5	136	115	0	34	33	34
2025	4	9	11	42	55	0.689	-0.128	3.563	0.013	0.01	0	43.4	34.4	77	135	114	0	34	34	34
2025	4	9	11	52	55	0.709	-0.092	3.56	0.013	0.01	0	43.4	35.7	72.2	135	115	0	34	32	34
2025	4	9	12	2	55	0.735	-0.075	3.56	0.01	0.007	0	43.4	35.7	77	135	115	0	34	32	34
2025	4	9	12	12	55	0.692	-0.082	3.56	0.013	0.01	0	43.4	35.3	75.3	135	115	0	34	33	34
2025	4	9	12	22	55	0.676	-0.089	3.56	0.013	0.01	0	43.9	36.1	62.4	136	116	0	34	32	34
2025	4	9	12	32	55	0.725	-0.089	3.56	0.01	0.007	0	43.4	34.8	77.4	135	114	0	34	33	34
2025	4	9	12	42	55	0.669	-0.095	3.56	0.013	0.01	0	44.3	35.7	61.1	136	116	0	33	33	33
2025	4	9	12	52	55	0.692	-0.075	3.56	0.016	0.013	0	44.7	36.1	71.8	138	117	0	34	33	34
2025	4	9	13	2	55	0.709	-0.092	3.56	0.013	0.01	0	43.9	35.3	59.8	137	116	0	35	34	33
2025	4	9	13	12	55	0.692	-0.079	3.56	0.01	0.007	0	43.9	35.3	50.7	136	115	0	34	33	34
2025	4	9	13	22	55	0.699	-0.049	3.563	0.013	0.01	0	43.9	35.7	68.4	136	116	0	34	33	34
2025	4	9	13	32	55	0.712	-0.069	3.56	0.013	0.01	0	44.3	35.7	52.9	137	116	0	34	33	33
2025	4	9	13	42	55	0.715	-0.125	3.56	0.013	0.01	0	44.3	35.7	52.9	137	116	0	34	33	33
2025	4	9	13	52	55	0.696	-0.072	3.56	0.01	0.007	0	43.9	35.7	51.2	136	115	0	34	32	33
2025	4	9	14	2	55	0.728	-0.072	3.563	0.013	0.01	0	43.9	35.3	70.5	136	115	0	34	33	33
2025	4	9	14	12	55	0.738	-0.062	3.56	0.01	0.007	0	43.9	35.7	51.2	136	115	0	34	32	34
2025	4	9	14	22	55	0.705	-0.098	3.56	0.016	0.016	0	44.3	36.5	50.3	137	117	0	34	32	33
2025	4	9	14	32	55	0.666	-0.108	3.56	0.01	0.007	0	44.3	36.1	48.2	137	116	0	34	32	33
2025	4	9	14	42	55	0.735	-0.095	3.56	0.013	0.01	0	44.3	36.1	47.7	137	116	0	34	32	33
2025	4	9	14	52	55	0.728	-0.082	3.556	0.013	0.01	0	43.9	36.1	48.6	136	116	0	34	32	33
2025	4	9	15	2	55	0.705	-0.075	3.56	0.01	0.007	0	43.9	36.1	51.6	137	117	0	35	33	33
2025	4	9	15	12	55	0.686	-0.075	3.556	0.01	0.007	0	44.3	35.7	49	137	116	0	34	33	33
2025	4	9	15	22	55	0.699	-0.098	3.56	0.016	0.013	0	44.3	36.5	53.8	137	117	0	34	32	33
2025	4	9	15	32	55	0.689	-0.092	3.56	0.013	0.01	0	44.7	36.5	52.9	138	117	0	34	32	33
2025	4	9	15	42	55	0.689	-0.092	3.556	0.016	0.013	0	43.9	36.5	47.7	137	117	0	35	32	34
2025	4	9	15	52	55	0.709	-0.079	3.556	0.01	0.007	0	44.3	36.5	50.7	137	117	0	34	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	9	16	2	55	0.745	-0.112	3.556	0.01	0.007	0	43.9	36.1	52.9	137	116	0	35	32	33
2025	4	9	16	12	55	0.689	-0.115	3.556	0.013	0.01	0	44.7	35.7	52	138	116	0	34	33	33
2025	4	9	16	22	55	0.728	-0.105	3.556	0.013	0.01	0	43.9	35.7	49.9	136	115	0	34	32	33
2025	4	9	16	32	55	0.719	-0.075	3.556	0.016	0.013	0	44.7	36.5	54.6	138	118	0	34	33	33
2025	4	9	16	42	55	0.712	-0.089	3.553	0.013	0.01	0	44.7	36.5	47.7	138	118	0	34	33	33
2025	4	9	16	52	55	0.689	-0.066	3.553	0.01	0.007	0	44.7	36.1	51.6	137	117	0	33	33	34
2025	4	9	17	2	55	0.712	-0.092	3.556	0.016	0.013	0	45.6	37.4	62.8	140	119	0	34	32	33
2025	4	9	17	12	55	0.705	-0.105	3.556	0.016	0.016	0	45.2	37	67.5	139	119	0	34	33	34
2025	4	9	17	22	55	0.745	-0.079	3.56	0.01	0.007	0	44.7	36.1	75.3	138	117	0	34	33	33
2025	4	9	17	32	55	0.728	-0.082	3.556	0.013	0.01	0	44.7	36.5	74.4	138	117	0	34	32	34
2025	4	9	17	42	55	0.722	-0.105	3.556	0.01	0.007	0	44.7	37	74.8	138	118	0	34	32	33
2025	4	9	17	52	55	0.702	-0.102	3.556	0.01	0.007	0	45.2	36.5	74.8	138	117	0	33	32	33
2025	4	9	18	2	55	0.738	-0.092	3.556	0.01	0.007	0	44.7	37	74.8	139	118	0	35	32	33
2025	4	9	18	12	55	0.735	-0.095	3.556	0.01	0.007	0	45.2	37	74	139	118	0	34	32	34
2025	4	9	18	22	55	0.725	-0.059	3.556	0.013	0.01	0	45.6	37	74	140	119	0	34	33	33
2025	4	9	18	32	55	0.722	-0.089	3.556	0.013	0.01	0	45.2	36.5	74	139	118	0	34	33	33
2025	4	9	18	42	55	0.709	-0.125	3.556	0.013	0.01	0	46	37.4	74	140	119	0	33	32	34
2025	4	9	18	52	55	0.709	-0.079	3.556	0.013	0.01	0	46	37.8	73.1	141	120	0	34	32	33
2025	4	9	19	2	55	0.699	-0.098	3.556	0.013	0.01	0	46	37.8	72.2	141	121	0	34	33	34
2025	4	9	19	12	55	0.715	-0.075	3.553	0.013	0.01	0	46.4	37.8	71.8	142	121	0	34	33	34
2025	4	9	19	22	55	0.676	-0.062	3.553	0.013	0.01	0	46.9	38.7	73.5	143	122	0	34	32	34
2025	4	9	19	32	55	0.725	-0.092	3.553	0.016	0.013	0	46.9	38.3	74.4	143	122	0	34	33	33
2025	4	9	19	42	55	0.712	-0.056	3.553	0.016	0.013	0	46.9	38.3	74	143	122	0	34	33	34
2025	4	9	19	52	55	0.709	-0.095	3.553	0.016	0.013	0	47.3	38.7	74	143	123	0	33	33	33
2025	4	9	20	2	55	0.741	-0.098	3.553	0.016	0.013	0	46.9	38.7	74.4	143	122	0	34	32	33
2025	4	9	20	12	55	0.735	-0.095	3.553	0.016	0.013	0	46.9	39.1	73.5	143	123	0	34	32	33
2025	4	9	20	22	55	0.696	-0.108	3.553	0.01	0.007	0	46.9	38.3	74	143	122	0	34	33	33
2025	4	9	20	32	55	0.709	-0.089	3.553	0.016	0.016	0	46.4	38.7	74.8	142	122	0	34	32	34
2025	4	9	20	42	55	0.699	-0.056	3.553	0.016	0.013	0	46.9	38.7	73.5	143	122	0	34	32	33
2025	4	9	20	52	55	0.696	-0.095	3.553	0.016	0.013	0	46.4	37.8	74.4	142	121	0	34	33	34
2025	4	9	21	2	55	0.692	-0.069	3.553	0.013	0.01	0	46	37.4	74.8	141	120	0	34	33	33
2025	4	9	21	12	55	0.728	-0.069	3.553	0.013	0.01	0	46	37.4	74.8	141	121	0	34	34	33
2025	4	9	21	22	55	0.738	-0.128	3.553	0.013	0.01	0	45.6	37.4	74.4	140	120	0	34	33	33
2025	4	9	21	32	55	0.725	-0.075	3.553	0.013	0.01	0	46	37.8	74.4	141	121	0	34	33	34
2025	4	9	21	42	55	0.712	-0.095	3.55	0.013	0.01	0	46	37.8	74.4	141	120	0	34	32	34
2025	4	9	21	52	55	0.709	-0.098	3.55	0.013	0.01	0	46.4	37.8	74.4	142	121	0	34	33	34
2025	4	9	22	2	55	0.705	-0.085	3.55	0.013	0.01	0	46.4	37.8	74.8	142	121	0	34	33	33
2025	4	9	22	12	55	0.705	-0.105	3.55	0.013	0.01	0	47.3	38.3	74.8	143	122	0	33	33	34
2025	4	9	22	22	55	0.735	-0.092	3.55	0.013	0.01	0	46.4	38.3	74.8	142	122	0	34	33	34
2025	4	9	22	32	55	0.696	-0.075	3.55	0.013	0.01	0	46.4	37.8	73.1	142	121	0	34	33	34
2025	4	9	22	42	55	0.702	-0.075	3.55	0.016	0.013	0	46.4	37.8	74.8	142	122	0	34	34	34
2025	4	9	22	52	55	0.702	-0.082	3.55	0.016	0.013	0	46	37.4	75.7	141	120	0	34	33	34
2025	4	9	23	2	55	0.686	-0.121	3.55	0.01	0.007	0	45.6	37.4	75.7	140	120	0	34	33	33
2025	4	9	23	12	55	0.715	-0.072	3.55	0.016	0.016	0	46	37.4	75.3	141	120	0	34	33	34
2025	4	9	23	22	55	0.676	-0.089	3.55	0.013	0.01	0	46.4	37.4	74.8	142	121	0	34	34	34
2025	4	9	23	32	55	0.702	-0.066	3.55	0.013	0.01	0	46.4	37.8	74.8	142	121	0	34	33	34
2025	4	9	23	42	55	0.722	-0.069	3.55	0.013	0.01	0	46	37.4	74.8	141	121	0	34	34	34
2025	4	9	23	52	55	0.699	-0.108	3.55	0.013	0.01	0	46.4	37.8	75.7	142	121	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	10	0	2	55	0.728	-0.072	3.55	0.01	0.007	0	46	37.8	75.3	142	122	0	35	34	34
2025	4	10	0	12	55	0.732	-0.085	3.55	0.013	0.01	0	45.6	37.8	75.3	141	121	0	35	33	34
2025	4	10	0	22	55	0.758	-0.079	3.55	0.013	0.01	0	45.6	37.8	75.7	141	121	0	35	33	34
2025	4	10	0	32	55	0.715	-0.105	3.547	0.016	0.013	0	45.6	37.8	75.3	141	121	0	35	33	34
2025	4	10	0	42	55	0.755	-0.059	3.55	0.01	0.007	0	46.4	38.3	76.5	142	122	0	34	33	33
2025	4	10	0	52	55	0.712	-0.085	3.547	0.01	0.007	0	46.4	38.3	76.1	142	122	0	34	33	34
2025	4	10	1	2	55	0.679	-0.095	3.547	0.013	0.01	0	46.4	38.3	76.1	142	122	0	34	33	34
2025	4	10	1	12	55	0.728	-0.072	3.547	0.01	0.007	0	46.4	38.3	75.7	142	122	0	34	33	34
2025	4	10	1	22	55	0.715	-0.128	3.547	0.013	0.01	0	46.4	37.8	75.3	142	121	0	34	33	34
2025	4	10	1	32	55	0.692	-0.089	3.547	0.01	0.007	0	46	37.8	75.7	142	121	0	35	33	34
2025	4	10	1	42	55	0.699	-0.118	3.547	0.01	0.007	0	46.4	37.8	77	142	121	0	34	33	33
2025	4	10	1	52	55	0.699	-0.062	3.547	0.016	0.013	0	46.4	37.8	77	142	122	0	34	34	33
2025	4	10	2	2	55	0.755	-0.075	3.547	0.01	0.007	0	47.3	38.3	74.4	145	122	0	35	33	34
2025	4	10	2	12	55	0.689	-0.079	3.547	0.01	0.007	0	47.7	37.8	74.4	145	122	0	34	34	33
2025	4	10	2	22	55	0.728	-0.082	3.547	0.016	0.013	0	47.7	38.3	74.4	145	122	0	34	33	33
2025	4	10	2	32	55	0.719	-0.089	3.547	0.013	0.01	0	47.3	38.3	73.5	145	122	0	35	33	34
2025	4	10	2	42	55	0.738	-0.121	3.547	0.01	0.007	0	47.7	37.8	74	145	122	0	34	34	34
2025	4	10	2	52	55	0.699	-0.092	3.547	0.013	0.01	0	47.7	38.7	74.4	145	122	0	34	32	33
2025	4	10	3	2	55	0.722	-0.092	3.547	0.016	0.013	0	47.3	38.3	74	145	122	0	35	33	34
2025	4	10	3	12	55	0.699	-0.102	3.547	0.013	0.01	0	47.7	38.3	74.4	145	122	0	34	33	34
2025	4	10	3	22	55	0.712	-0.089	3.547	0.016	0.013	0	47.7	38.3	74.4	145	122	0	34	33	33
2025	4	10	3	32	55	0.696	-0.069	3.547	0.016	0.013	0	47.7	38.3	74.8	145	122	0	34	33	34
2025	4	10	3	42	55	0.725	-0.075	3.547	0.016	0.013	0	47.7	38.3	75.3	145	122	0	34	33	33
2025	4	10	3	52	55	0.719	-0.115	3.547	0.013	0.01	0	47.3	38.7	74.8	144	122	0	34	32	34
2025	4	10	4	2	55	0.725	-0.059	3.547	0.01	0.007	0	47.7	38.3	74.4	145	122	0	34	33	34
2025	4	10	4	12	55	0.755	-0.085	3.547	0.013	0.01	0	47.3	38.3	73.5	144	122	0	34	33	34
2025	4	10	4	22	55	0.719	-0.089	3.547	0.01	0.007	0	47.3	38.3	74.4	145	122	0	35	33	35
2025	4	10	4	32	55	0.725	-0.082	3.547	0.013	0.01	0	47.3	38.3	74.8	144	122	0	34	33	34
2025	4	10	4	42	55	0.692	-0.072	3.547	0.013	0.01	0	46.9	38.3	75.3	144	122	0	35	33	34
2025	4	10	4	52	55	0.748	-0.102	3.547	0.016	0.013	0	47.3	37.8	74.4	144	121	0	34	33	34
2025	4	10	5	2	55	0.732	-0.079	3.547	0.01	0.007	0	47.7	37.8	74.8	144	121	0	33	33	35
2025	4	10	5	12	55	0.686	-0.105	3.547	0.013	0.01	0	46.9	38.3	75.7	143	121	0	34	32	34
2025	4	10	5	22	55	0.735	-0.075	3.543	0.01	0.007	0	46	37.4	74.8	142	120	0	35	33	34
2025	4	10	5	32	55	0.712	-0.075	3.547	0.016	0.016	0	46.4	37	74	142	119	0	34	33	35
2025	4	10	5	42	55	0.709	-0.105	3.543	0.016	0.013	0	46	37.4	74.8	142	119	0	35	32	33
2025	4	10	5	52	55	0.699	-0.075	3.547	0.01	0.007	0	45.2	36.5	75.3	140	118	0	35	33	34
2025	4	10	6	2	55	0.705	-0.128	3.547	0.01	0.007	0	45.2	36.1	75.7	139	117	0	34	33	34
2025	4	10	6	12	55	0.719	-0.092	3.547	0.016	0.016	0	43.9	35.3	75.7	138	115	0	36	33	34
2025	4	10	6	22	55	0.689	-0.079	3.543	0.013	0.01	0	44.7	34.8	74	138	115	0	34	34	35
2025	4	10	6	32	55	0.692	-0.066	3.547	0.01	0.007	0	44.3	34.8	76.5	137	114	0	34	33	33
2025	4	10	6	42	55	0.738	-0.085	3.547	0.01	0.007	0	43.9	34.8	76.1	136	114	0	34	33	34
2025	4	10	6	52	55	0.758	-0.089	3.547	0.01	0.007	0	44.3	34	76.1	137	113	0	34	34	34
2025	4	10	7	2	55	0.712	-0.102	3.547	0.01	0.007	0	43.4	34	76.5	136	112	0	35	33	34
2025	4	10	7	12	55	0.715	-0.105	3.547	0.01	0.007	0	43.9	34.4	75.7	136	113	0	34	33	35
2025	4	10	7	22	55	0.712	-0.079	3.547	0.013	0.01	0	43.4	34.4	75.7	136	113	0	35	33	34
2025	4	10	7	32	55	0.728	-0.085	3.547	0.01	0.007	0	43.9	34.8	76.1	136	113	0	34	32	34
2025	4	10	7	42	55	0.689	-0.079	3.547	0.01	0.007	0	43.9	35.7	75.7	136	115	0	34	32	34
2025	4	10	7	52	55	0.689	-0.062	3.547	0.016	0.016	0	44.3	35.7	75.3	138	115	0	35	32	34

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	4	10	8	2	55	0.715	-0.066	3.547	0.013	0.01	0	44.3	35.3	74.8	137	115	0	34	33	35	
2025	4	10	8	12	55	0.728	-0.052	3.547	0.013	0.01	0	44.3	35.3	75.7	137	115	0	34	33	34	
2025	4	10	8	22	55	0.715	-0.105	3.547	0.01	0.007	0	43.9	36.1	76.1	137	116	0	35	32	34	
2025	4	10	8	32	55	0.702	-0.085	3.547	0.013	0.01	0	44.3	35.3	75.7	137	115	0	34	33	34	
2025	4	10	8	42	55	0.715	-0.082	3.547	0.013	0.01	0	45.6	37	75.3	140	118	0	34	32	34	
2025	4	10	8	52	55	0.702	-0.112	3.547	0.01	0.007	0	45.2	36.1	74.8	139	117	0	34	33	34	
2025	4	10	9	2	55	0.709	-0.066	3.547	0.013	0.01	0	46	37	75.7	141	119	0	34	33	33	
2025	4	10	9	12	55	0.686	-0.075	3.547	0.016	0.013	0	44.7	35.3	75.3	138	115	0	34	33	34	
2025	4	10	9	22	55	0.715	-0.131	3.547	0.013	0.01	0	43.9	35.3	75.7	136	115	0	34	33	34	
2025	4	10	9	32	55	0.62	-0.069	3.547	0.016	0.013	0	44.7	35.7	75.3	138	116	0	34	33	34	
2025	4	10	9	42	55	0.719	-0.092	3.547	0.013	0.01	0	43.9	34.8	75.3	137	114	0	35	33	34	
2025	4	10	9	52	55	0.682	-0.092	3.547	0.016	0.016	0	44.3	35.3	74	137	114	0	34	32	34	
2025	4	10	10	2	55	0.692	-0.072	3.543	0.016	0.016	0	44.3	35.7	73.5	137	115	0	34	32	34	
2025	4	10	10	12	55	0.709	-0.118	3.54	0.013	0.01	0	43.9	35.3	64.5	136	114	0	34	32	34	
2025	4	10	10	22	55	0.676	-0.069	3.537	0.016	0.013	0	43.9	34.8	54.6	136	114	0	34	33	34	
2025	4	10	10	32	55	0.699	-0.072	3.54	0.016	0.013	0	44.3	35.3	50.7	137	115	0	34	33	34	
2025	4	10	10	42	55	0.669	-0.079	3.54	0.013	0.01	0	44.7	35.7	51.2	138	116	0	34	33	34	
2025	4	10	10	52	55	0.689	-0.075	3.54	0.016	0.013	0	44.3	35.3	50.7	137	115	0	34	33	33	
2025	4	10	11	2	55	0.692	-0.079	3.537	0.013	0.01	0	44.3	35.3	52.5	137	115	0	34	33	34	
2025	4	10	11	12	55	0.735	-0.079	3.54	0.016	0.013	0	43.9	34.8	50.3	136	114	0	34	33	34	
2025	4	10	11	22	55	0.682	-0.075	3.54	0.016	0.016	0	44.3	35.3	48.2	137	115	0	34	33	33	
2025	4	10	11	32	55	0.702	-0.092	3.54	0.013	0.01	0	43.4	34.4	47.7	136	113	0	35	33	34	
2025	4	10	11	42	55	0.666	-0.095	3.54	0.013	0.01	0	43.9	34.4	50.3	136	113	0	34	33	33	
2025	4	10	11	52	55	0.715	-0.095	3.537	0.01	0.007	0	43.9	35.3	49	136	114	0	34	32	33	
2025	4	10	12	2	55	0.663	-0.079	3.54	0.013	0.01	0	44.3	35.3	51.6	137	115	0	34	33	33	
2025	4	10	12	12	55	0.699	-0.112	3.54	0.01	0.007	0	44.3	35.3	47.3	136	115	0	33	33	33	
2025	4	10	12	22	55	0.682	-0.102	3.54	0.01	0.007	0	43.9	34.8	47.7	136	114	0	34	33	34	
2025	4	10	12	32	55	0.692	-0.112	3.54	0.016	0.016	0	43.9	35.3	48.6	136	114	0	34	32	34	
2025	4	10	12	42	55	0.666	-0.085	3.54	0.013	0.01	0	43.9	35.3	50.3	136	114	0	34	32	33	
2025	4	10	12	52	55	0.705	-0.105	3.54	0.016	0.013	0	43.9	34.8	49	136	114	0	34	33	33	
2025	4	10	13	2	55	0.728	-0.108	3.54	0.016	0.013	0	43.9	35.3	49.5	136	114	0	34	32	34	
2025	4	10	13	12	55	0.705	-0.079	3.54	0.016	0.013	0	43.9	35.3	49.5	136	114	0	34	32	33	
2025	4	10	13	22	55	0.699	-0.095	3.54	0.013	0.01	0	43.4	34.8	48.6	135	114	0	34	33	33	
2025	4	10	13	32	55	0.689	-0.043	3.54	0.013	0.01	0	44.7	35.3	48.2	137	115	0	33	33	34	
2025	4	10	13	42	55	0.676	-0.102	3.54	0.013	0.01	0	43.9	34.8	49.5	136	114	0	34	33	33	
2025	4	10	13	52	55	0.715	-0.069	3.537	0.01	0.007	0	44.3	34.8	49.5	136	114	0	33	33	33	
2025	4	10	14	2	55	0.679	-0.082	3.54	0.013	0.01	0	43.9	35.3	50.3	136	114	0	34	32	34	
2025	4	10	14	12	55	0.692	-0.082	3.54	0.013	0.01	0	44.3	35.3	49.5	137	115	0	34	33	33	
2025	4	10	14	22	55	0.705	-0.121	3.54	0.016	0.013	0	44.3	35.3	49.9	137	115	0	34	33	33	
2025	4	10	14	32	55	0.682	-0.085	3.54	0.013	0.01	0	44.3	35.3	50.7	137	115	0	34	33	32	
2025	4	10	14	42	55	0.689	-0.085	3.54	0.01	0.007	0	44.3	35.3	46.9	137	115	0	34	33	33	
2025	4	10	14	52	55	0.702	-0.066	3.54	0.016	0.013	0	44.7	35.3	49.5	137	115	0	33	33	33	
2025	4	10	15	2	55	0.715	-0.075	3.54	0.016	0.016	0	44.3	35.3	50.3	136	114	0	33	32	32	
2025	4	10	15	12	55	0.741	-0.089	3.54	0.013	0.01	0	44.3	35.3	52.9	137	114	0	34	32	34	
2025	4	10	15	22	55	0.709	-0.066	3.54	0.01	0.007	0	43.9	35.3	48.2	136	114	0	34	32	33	
2025	4	10	15	32	55	0.715	-0.069	3.54	0.01	0.007	0	44.7	36.1	52.9	137	116	0	33	32	33	
2025	4	10	15	42	55	0.719	-0.108	3.54	0.01	0.007	0	44.3	35.7	52.5	137	116	0	34	33	33	
2025	4	10	15	52	55	0.728	-0.079	3.54	0.016	0.016	0	44.7	36.1	56.3	138	116	0	34	32	32	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	10	16	2	55	0.705	-0.069	3.54	0.013	0.01	0	45.2	36.1	49	138	116	0	33	32	33
2025	4	10	16	12	55	0.705	-0.095	3.54	0.016	0.013	0	45.2	36.1	55	138	116	0	33	32	33
2025	4	10	16	22	55	0.712	-0.108	3.54	0.01	0.007	0	44.7	35.3	60.2	138	115	0	34	33	33
2025	4	10	16	32	55	0.709	-0.072	3.54	0.013	0.01	0	44.7	35.7	48.6	138	115	0	34	32	33
2025	4	10	16	42	55	0.666	-0.059	3.54	0.013	0.01	0	44.7	36.1	51.6	138	116	0	34	32	33
2025	4	10	16	52	55	0.728	-0.062	3.54	0.013	0.01	0	44.7	36.1	58	138	116	0	34	32	33
2025	4	10	17	2	55	0.709	-0.095	3.54	0.013	0.01	0	44.7	35.7	53.8	138	115	0	34	32	33
2025	4	10	17	12	55	0.689	-0.085	3.54	0.01	0.007	0	45.2	36.1	52.9	138	116	0	33	32	33
2025	4	10	17	22	55	0.728	-0.089	3.54	0.016	0.013	0	45.2	35.7	49.9	139	116	0	34	33	33
2025	4	10	17	32	55	0.696	-0.089	3.54	0.016	0.013	0	44.7	36.1	54.2	138	116	0	34	32	33
2025	4	10	17	42	55	0.738	-0.059	3.54	0.01	0.007	0	45.6	35.7	63.2	139	116	0	33	33	32
2025	4	10	17	52	55	0.725	-0.121	3.54	0.013	0.01	0	45.2	36.5	73.5	139	117	0	34	32	34
2025	4	10	18	2	55	0.732	-0.079	3.543	0.013	0.01	0	45.6	36.5	74.8	140	117	0	34	32	33
2025	4	10	18	12	55	0.692	-0.049	3.543	0.013	0.01	0	45.6	37	74.8	140	118	0	34	32	33
2025	4	10	18	22	55	0.712	-0.098	3.543	0.016	0.013	0	46	36.5	74	140	117	0	33	32	33
2025	4	10	18	32	55	0.709	-0.066	3.543	0.01	0.007	0	46.4	37	74.4	141	119	0	33	33	33
2025	4	10	18	42	55	0.722	-0.075	3.543	0.013	0.01	0	46.4	37.4	69.2	142	119	0	34	32	33
2025	4	10	18	52	55	0.682	-0.075	3.543	0.013	0.01	0	46.9	37.4	73.5	142	120	0	33	33	33
2025	4	10	19	2	55	0.669	-0.105	3.543	0.01	0.007	0	47.7	38.3	73.5	145	122	0	34	33	33
2025	4	10	19	12	55	0.722	-0.075	3.543	0.013	0.01	0	47.7	38.7	73.5	145	122	0	34	32	33
2025	4	10	19	22	55	0.719	-0.089	3.543	0.013	0.01	0	47.3	38.3	74.4	144	121	0	34	32	33
2025	4	10	19	32	55	0.748	-0.095	3.547	0.016	0.013	0	47.7	38.7	73.5	145	122	0	34	32	34
2025	4	10	19	42	55	0.705	-0.089	3.547	0.013	0.01	0	47.7	38.7	74.4	145	122	0	34	32	33
2025	4	10	19	52	55	0.712	-0.075	3.543	0.016	0.013	0	47.3	38.3	65.8	144	121	0	34	32	33
2025	4	10	20	2	55	0.686	-0.075	3.547	0.013	0.01	0	48.2	38.7	47.7	145	122	0	33	32	32
2025	4	10	20	12	55	0.692	-0.072	3.547	0.013	0.01	0	47.3	38.7	67.9	144	122	0	34	32	33
2025	4	10	20	22	55	0.709	-0.085	3.547	0.01	0.007	0	47.3	38.3	60.6	144	121	0	34	32	34
2025	4	10	20	32	55	0.709	-0.059	3.55	0.01	0.007	0	47.3	37.8	66.2	144	121	0	34	33	33
2025	4	10	20	42	55	0.705	-0.082	3.55	0.013	0.01	0	47.3	38.3	62.8	143	121	0	33	32	34
2025	4	10	20	52	55	0.722	-0.039	3.553	0.013	0.01	0	47.7	37.8	66.7	144	121	0	33	33	33
2025	4	10	21	2	55	0.735	-0.082	3.556	0.013	0.01	0	47.3	37.8	73.5	144	121	0	34	33	33
2025	4	10	21	12	55	0.682	-0.062	3.556	0.01	0.007	0	47.7	38.3	73.1	145	122	0	34	33	33
2025	4	10	21	22	55	0.689	-0.092	3.56	0.013	0.01	0	47.3	38.3	73.1	143	121	0	33	32	33
2025	4	10	21	32	55	0.705	-0.082	3.56	0.01	0.007	0	47.3	37.8	74	144	121	0	34	33	33
2025	4	10	21	42	55	0.732	-0.108	3.56	0.013	0.01	0	46.9	38.3	74.8	143	121	0	34	32	33
2025	4	10	21	52	55	0.741	-0.105	3.56	0.016	0.013	0	47.3	38.7	75.3	145	122	0	35	32	33
2025	4	10	22	2	55	0.715	-0.085	3.563	0.016	0.013	0	47.3	38.7	76.1	144	122	0	34	32	33
2025	4	10	22	12	55	0.673	-0.082	3.563	0.013	0.01	0	47.3	37.8	74.8	144	121	0	34	33	33
2025	4	10	22	22	55	0.771	-0.082	3.563	0.01	0.007	0	47.3	37.8	76.1	144	121	0	34	33	33
2025	4	10	22	32	55	0.768	-0.085	3.563	0.016	0.013	0	47.3	38.7	74.4	144	122	0	34	32	34
2025	4	10	22	42	55	0.738	-0.089	3.563	0.01	0.007	0	47.3	38.3	76.5	144	122	0	34	33	34
2025	4	10	22	52	55	0.728	-0.075	3.566	0.016	0.016	0	47.3	38.7	77	144	122	0	34	32	33
2025	4	10	23	2	55	0.728	-0.085	3.566	0.016	0.013	0	47.7	38.3	76.1	145	122	0	34	33	33
2025	4	10	23	12	55	0.722	-0.098	3.566	0.013	0.01	0	47.7	38.3	75.7	144	122	0	33	33	34
2025	4	10	23	22	55	0.702	-0.062	3.566	0.013	0.01	0	47.3	39.1	75.3	145	123	0	35	32	33
2025	4	10	23	32	55	0.686	-0.102	3.566	0.013	0.01	0	47.7	38.7	74.4	145	123	0	34	33	33
2025	4	10	23	42	55	0.755	-0.112	3.566	0.016	0.013	0	47.3	38.3	74.4	144	122	0	34	33	33
2025	4	10	23	52	55	0.745	-0.095	3.566	0.013	0.01	0	46.9	37.8	74.4	143	121	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	11	0	2	55	0.741	-0.089	3.566	0.01	0.007	0	46.9	38.3	74	143	122	0	34	33	34
2025	4	11	0	12	55	0.709	-0.069	3.566	0.016	0.013	0	47.3	38.7	74	144	122	0	34	32	33
2025	4	11	0	22	55	0.758	-0.098	3.57	0.01	0.007	0	47.3	38.7	73.1	144	122	0	34	32	34
2025	4	11	0	32	55	0.741	-0.072	3.57	0.013	0.01	0	46.9	37.8	73.5	143	121	0	34	33	33
2025	4	11	0	42	55	0.732	-0.082	3.57	0.01	0.007	0	46.9	38.3	73.1	143	121	0	34	32	33
2025	4	11	0	52	55	0.735	-0.105	3.57	0.01	0.007	0	47.3	38.7	72.2	144	122	0	34	32	33
2025	4	11	1	2	55	0.696	-0.085	3.57	0.016	0.013	0	47.3	38.3	71.8	144	122	0	34	33	33
2025	4	11	1	12	55	0.712	-0.095	3.573	0.013	0.01	0	47.3	38.3	71.4	144	122	0	34	33	34
2025	4	11	1	22	55	0.728	-0.069	3.576	0.01	0.007	0	46.4	37.8	71	143	121	0	35	33	34
2025	4	11	1	32	55	0.709	-0.082	3.579	0.013	0.01	0	47.3	38.7	71.8	144	122	0	34	32	33
2025	4	11	1	42	55	0.745	-0.089	3.583	0.01	0.007	0	46.9	38.3	72.2	143	121	0	34	32	33
2025	4	11	1	52	55	0.722	-0.105	3.586	0.016	0.013	0	46.9	37.8	71.4	143	121	0	34	33	34
2025	4	11	2	2	55	0.748	-0.082	3.586	0.01	0.007	0	46.9	38.3	72.2	143	121	0	34	32	34
2025	4	11	2	12	55	0.715	-0.098	3.586	0.013	0.01	0	47.3	37.8	71.4	144	121	0	34	33	34
2025	4	11	2	22	55	0.732	-0.075	3.589	0.013	0.01	0	47.3	37.8	74	144	121	0	34	33	33
2025	4	11	2	32	55	0.761	-0.069	3.589	0.013	0.01	0	46.9	37.8	73.5	143	121	0	34	33	34
2025	4	11	2	42	55	0.712	-0.092	3.589	0.013	0.01	0	47.3	37.8	73.1	144	121	0	34	33	34
2025	4	11	2	52	55	0.768	-0.115	3.593	0.013	0.01	0	46.4	37.4	75.3	142	120	0	34	33	34
2025	4	11	3	2	55	0.768	-0.072	3.593	0.01	0.007	0	47.3	37.4	74.8	144	120	0	34	33	34
2025	4	11	3	12	55	0.709	-0.092	3.593	0.013	0.01	0	47.7	37.8	75.3	145	121	0	34	33	34
2025	4	11	3	22	55	0.751	-0.102	3.596	0.01	0.007	0	47.3	37.8	74.4	145	121	0	35	33	34
2025	4	11	3	32	55	0.715	-0.098	3.596	0.016	0.013	0	47.7	37.4	74.8	145	120	0	34	33	34
2025	4	11	3	42	55	0.728	-0.085	3.596	0.01	0.007	0	47.3	37.4	76.1	144	120	0	34	33	33
2025	4	11	3	52	55	0.679	-0.092	3.596	0.013	0.01	0	47.7	37.4	75.3	145	121	0	34	34	34
2025	4	11	4	2	55	0.735	-0.079	3.596	0.01	0.007	0	47.7	37.4	74.8	145	120	0	34	33	33
2025	4	11	4	12	55	0.741	-0.105	3.596	0.013	0.01	0	47.3	37.4	74.8	144	120	0	34	33	33
2025	4	11	4	22	55	0.732	-0.072	3.596	0.016	0.013	0	47.3	38.3	74.4	144	121	0	34	32	34
2025	4	11	4	32	55	0.732	-0.075	3.596	0.013	0.01	0	47.7	37.4	74.4	145	120	0	34	33	34
2025	4	11	4	42	55	0.715	-0.092	3.599	0.01	0.007	0	47.7	37.8	73.5	145	121	0	34	33	34
2025	4	11	4	52	55	0.758	-0.125	3.599	0.013	0.01	0	47.3	37.8	74	144	120	0	34	32	34
2025	4	11	5	2	55	0.732	-0.072	3.599	0.01	0.007	0	47.3	37.8	74	144	120	0	34	32	34
2025	4	11	5	12	55	0.741	-0.072	3.602	0.01	0.007	0	46.9	37.4	73.5	144	120	0	35	33	33
2025	4	11	5	22	55	0.722	-0.085	3.602	0.01	0.007	0	46.9	37	73.5	143	119	0	34	33	33
2025	4	11	5	32	55	0.823	-0.072	3.602	0.016	0.013	0	46.9	37	73.1	142	119	0	33	33	34
2025	4	11	5	42	55	0.728	-0.069	3.602	0.016	0.013	0	46.4	37	74	142	119	0	34	33	33
2025	4	11	5	52	55	0.774	-0.115	3.602	0.01	0.007	0	46.4	36.5	73.1	142	118	0	34	33	33
2025	4	11	6	2	55	0.735	-0.085	3.606	0.016	0.013	0	46	36.1	73.1	141	117	0	34	33	34
2025	4	11	6	12	55	0.781	-0.092	3.606	0.016	0.013	0	46	36.1	73.1	141	117	0	34	33	34
2025	4	11	6	22	55	0.758	-0.098	3.606	0.01	0.007	0	46	36.1	72.7	141	117	0	34	33	34
2025	4	11	6	32	55	0.751	-0.092	3.609	0.016	0.013	0	45.6	36.1	73.1	140	117	0	34	33	33
2025	4	11	6	42	55	0.781	-0.072	3.609	0.013	0.01	0	45.6	36.1	73.1	140	117	0	34	33	33
2025	4	11	6	52	55	0.748	-0.072	3.612	0.013	0.01	0	45.2	35.3	72.7	139	116	0	34	34	34
2025	4	11	7	2	55	0.758	-0.089	3.615	0.013	0.01	0	45.2	36.1	73.1	139	116	0	34	32	33
2025	4	11	7	12	55	0.705	-0.075	3.619	0.013	0.01	0	45.2	36.1	73.1	139	117	0	34	33	33
2025	4	11	7	22	55	0.692	-0.075	3.622	0.013	0.01	0	45.2	35.7	72.7	139	116	0	34	33	34
2025	4	11	7	32	55	0.764	-0.089	3.622	0.01	0.007	0	44.7	35.7	71.4	139	116	0	35	33	34
2025	4	11	7	42	55	0.709	-0.089	3.625	0.013	0.01	0	45.6	37	72.7	140	118	0	34	32	33
2025	4	11	7	52	55	0.755	-0.082	3.625	0.01	0.007	0	45.6	36.5	73.5	140	118	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	11	8	2	55	0.735	-0.079	3.625	0.01	0.007	0	45.2	36.1	72.7	139	117	0	34	33	34
2025	4	11	8	12	55	0.771	-0.075	3.629	0.013	0.01	0	46	37	74	141	119	0	34	33	34
2025	4	11	8	22	55	0.735	-0.112	3.629	0.013	0.01	0	44.7	35.7	75.3	138	116	0	34	33	33
2025	4	11	8	32	55	0.758	-0.108	3.629	0.013	0.01	0	45.2	36.1	74.8	138	116	0	33	32	34
2025	4	11	8	42	55	0.791	-0.092	3.632	0.016	0.013	0	44.7	35.7	75.7	138	116	0	34	33	33
2025	4	11	8	52	55	0.768	-0.052	3.632	0.013	0.01	0	45.2	36.1	75.7	139	117	0	34	33	34
2025	4	11	9	2	55	0.741	-0.115	3.632	0.013	0.01	0	45.2	36.5	75.3	139	117	0	34	32	34
2025	4	11	9	12	55	0.768	-0.092	3.635	0.013	0.01	0	45.2	36.1	76.1	139	117	0	34	33	34
2025	4	11	9	22	55	0.715	-0.046	3.635	0.01	0.007	0	45.2	36.5	76.1	139	117	0	34	32	34
2025	4	11	9	32	55	0.781	-0.072	3.635	0.01	0.007	0	45.2	36.1	76.5	139	117	0	34	33	34
2025	4	11	9	42	55	0.741	-0.102	3.638	0.01	0.007	0	45.2	36.1	75.7	139	117	0	34	33	33
2025	4	11	9	52	55	0.764	-0.105	3.638	0.016	0.016	0	45.6	37	75.7	140	118	0	34	32	34
2025	4	11	10	2	55	0.745	-0.095	3.638	0.01	0.007	0	45.6	36.1	75.7	139	117	0	33	33	34
2025	4	11	10	12	55	0.768	-0.112	3.642	0.013	0.01	0	46.4	37.4	76.1	141	119	0	33	32	34
2025	4	11	10	22	55	0.719	-0.079	3.642	0.01	0.007	0	45.6	36.1	73.1	140	117	0	34	33	34
2025	4	11	10	32	55	0.758	-0.085	3.642	0.016	0.013	0	45.2	36.5	54.2	139	117	0	34	32	34
2025	4	11	10	42	55	0.751	-0.105	3.645	0.016	0.016	0	46	36.1	76.5	140	117	0	33	33	34
2025	4	11	10	52	55	0.738	-0.108	3.642	0.01	0.007	0	45.2	35.7	52.5	139	116	0	34	33	34
2025	4	11	11	2	55	0.741	-0.085	3.645	0.01	0.007	0	45.2	35.7	57.2	138	116	0	33	33	34
2025	4	11	11	12	55	0.781	-0.102	3.648	0.013	0.01	0	45.2	35.7	72.2	138	116	0	33	33	34
2025	4	11	11	22	55	0.778	-0.075	3.648	0.013	0.01	0	45.2	36.5	77	139	116	0	34	31	34
2025	4	11	11	32	55	0.748	-0.102	3.648	0.016	0.013	0	44.7	36.1	61.1	138	116	0	34	32	33
2025	4	11	11	42	55	0.735	-0.121	3.648	0.016	0.013	0	44.3	34.8	55.9	136	114	0	33	33	33
2025	4	11	11	52	55	0.722	-0.079	3.648	0.01	0.007	0	44.3	35.7	49	137	115	0	34	32	33
2025	4	11	12	2	55	0.719	-0.082	3.648	0.013	0.01	0	44.3	36.1	44.7	137	116	0	34	32	33
2025	4	11	12	12	55	0.715	-0.085	3.652	0.013	0.01	0	44.3	35.7	44.7	137	116	0	34	33	33
2025	4	11	12	22	55	0.741	-0.059	3.652	0.013	0.01	0	44.3	35.7	49.5	137	115	0	34	32	34
2025	4	11	12	32	55	0.741	-0.089	3.652	0.013	0.01	0	44.3	35.3	48.6	137	115	0	34	33	33
2025	4	11	12	42	55	0.758	-0.098	3.655	0.013	0.01	0	44.3	35.7	55	137	115	0	34	32	33
2025	4	11	12	52	55	0.741	-0.069	3.652	0.01	0.007	0	44.7	35.7	46.9	138	115	0	34	32	33
2025	4	11	13	2	55	0.748	-0.085	3.655	0.016	0.013	0	44.3	35.7	48.6	137	115	0	34	32	33
2025	4	11	13	12	55	0.741	-0.098	3.655	0.013	0.01	0	45.2	35.7	45.6	138	116	0	33	33	33
2025	4	11	13	22	55	0.715	-0.135	3.655	0.016	0.016	0	45.2	36.5	45.6	139	117	0	34	32	33
2025	4	11	13	32	55	0.738	-0.108	3.658	0.013	0.01	0	45.2	35.7	49	138	115	0	33	32	33
2025	4	11	13	42	55	0.738	-0.095	3.658	0.013	0.01	0	44.7	35.3	47.7	138	115	0	34	33	33
2025	4	11	13	52	55	0.791	-0.105	3.658	0.013	0.01	0	44.7	36.1	48.6	138	116	0	34	32	33
2025	4	11	14	2	55	0.745	-0.075	3.658	0.016	0.013	0	44.7	36.1	46.9	138	116	0	34	32	33
2025	4	11	14	12	55	0.748	-0.079	3.658	0.013	0.01	0	45.6	36.1	47.7	139	116	0	33	32	33
2025	4	11	14	22	55	0.761	-0.105	3.658	0.013	0.01	0	45.6	36.1	47.7	139	117	0	33	33	33
2025	4	11	14	32	55	0.778	-0.095	3.661	0.01	0.007	0	45.2	36.5	48.2	139	117	0	34	32	32
2025	4	11	14	42	55	0.778	-0.072	3.661	0.013	0.01	0	45.2	36.5	46	139	117	0	34	32	33
2025	4	11	14	52	55	0.771	-0.108	3.665	0.013	0.01	0	45.6	36.5	46	139	117	0	33	32	33
2025	4	11	15	2	55	0.771	-0.102	3.661	0.013	0.01	0	45.2	36.1	48.6	139	116	0	34	32	33
2025	4	11	15	12	55	0.761	-0.102	3.661	0.013	0.01	0	45.2	35.7	47.7	138	115	0	33	32	33
2025	4	11	15	22	55	0.778	-0.092	3.665	0.016	0.013	0	45.2	36.5	45.2	139	117	0	34	32	33
2025	4	11	15	32	55	0.748	-0.056	3.665	0.013	0.01	0	44.7	35.7	49.9	138	115	0	34	32	33
2025	4	11	15	42	55	0.758	-0.082	3.668	0.01	0.007	0	45.2	35.3	45.2	138	114	0	33	32	33
2025	4	11	15	52	55	0.728	-0.085	3.668	0.01	0.007	0	45.2	36.1	48.2	139	116	0	34	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	11	16	2	55	0.758	-0.049	3.671	0.016	0.013	0	45.2	36.1	46.4	139	116	0	34	32	33
2025	4	11	16	12	55	0.732	-0.049	3.668	0.013	0.01	0	46	36.5	45.2	140	117	0	33	32	32
2025	4	11	16	22	55	0.755	-0.075	3.668	0.016	0.013	0	45.2	36.5	45.6	139	117	0	34	32	33
2025	4	11	16	32	55	0.781	-0.075	3.668	0.01	0.007	0	45.6	36.5	46.4	140	117	0	34	32	33
2025	4	11	16	42	55	0.751	-0.066	3.671	0.013	0.01	0	45.6	36.1	46	139	117	0	33	33	32
2025	4	11	16	52	55	0.732	-0.079	3.671	0.016	0.013	0	45.2	36.1	46.9	139	117	0	34	33	33
2025	4	11	17	2	55	0.748	-0.108	3.671	0.013	0.01	0	45.2	36.5	46	139	117	0	34	32	33
2025	4	11	17	12	55	0.778	-0.075	3.671	0.01	0.007	0	46	36.5	49.5	140	118	0	33	33	33
2025	4	11	17	22	55	0.771	-0.092	3.671	0.016	0.013	0	46.4	37	45.6	141	118	0	33	32	33
2025	4	11	17	32	55	0.758	-0.089	3.671	0.016	0.013	0	45.6	36.1	46	140	117	0	34	33	33
2025	4	11	17	42	55	0.82	-0.062	3.675	0.013	0.01	0	46	37	46.9	140	118	0	33	32	33
2025	4	11	17	52	55	0.761	-0.082	3.675	0.013	0.01	0	46.4	37.4	69.2	141	119	0	33	32	33
2025	4	11	18	2	55	0.778	-0.089	3.675	0.013	0.01	0	46.4	37.4	48.2	141	119	0	33	32	32
2025	4	11	18	12	55	0.768	-0.066	3.675	0.016	0.013	0	46.4	37.4	58.9	142	119	0	34	32	33
2025	4	11	18	22	55	0.745	-0.079	3.678	0.013	0.01	0	47.3	37.8	52.9	143	120	0	33	32	33
2025	4	11	18	32	55	0.738	-0.085	3.684	0.013	0.01	0	47.3	37.8	72.2	143	121	0	33	33	33
2025	4	11	18	42	55	0.751	-0.092	3.684	0.013	0.01	0	47.3	38.3	73.5	144	121	0	34	32	33
2025	4	11	18	52	55	0.781	-0.052	3.684	0.013	0.01	0	47.3	38.3	73.1	144	122	0	34	33	33
2025	4	11	19	2	55	0.748	-0.069	3.684	0.01	0.007	0	47.7	38.3	50.7	145	122	0	34	33	34
2025	4	11	19	12	55	0.778	-0.105	3.684	0.016	0.013	0	47.7	39.1	57.6	145	123	0	34	32	33
2025	4	11	19	22	55	0.738	-0.062	3.684	0.016	0.013	0	48.2	39.6	48.2	146	123	0	34	31	33
2025	4	11	19	32	55	0.748	-0.069	3.684	0.013	0.01	0	47.7	38.7	52.5	145	122	0	34	32	33
2025	4	11	19	42	55	0.761	-0.079	3.684	0.016	0.013	0	47.7	38.7	56.8	145	122	0	34	32	33
2025	4	11	19	52	55	0.778	-0.089	3.688	0.01	0.007	0	47.3	38.3	72.7	144	122	0	34	33	33
2025	4	11	20	2	55	0.768	-0.092	3.688	0.016	0.013	0	47.7	38.3	51.2	144	121	0	33	32	34
2025	4	11	20	12	55	0.755	-0.092	3.688	0.01	0.007	0	47.7	37.8	54.2	144	121	0	33	33	33
2025	4	11	20	22	55	0.774	-0.092	3.688	0.016	0.013	0	47.7	37.8	57.2	144	120	0	33	32	33
2025	4	11	20	32	55	0.768	-0.105	3.688	0.013	0.01	0	46.9	37.8	75.3	143	120	0	34	32	33
2025	4	11	20	42	55	0.761	-0.108	3.691	0.013	0.01	0	46.9	37.8	73.5	143	120	0	34	32	32
2025	4	11	20	52	55	0.804	-0.092	3.688	0.013	0.01	0	47.7	38.3	49.9	145	122	0	34	33	33
2025	4	11	21	2	55	0.768	-0.095	3.688	0.016	0.013	0	47.3	38.3	59.8	144	121	0	34	32	33
2025	4	11	21	12	55	0.732	-0.079	3.688	0.013	0.01	0	47.3	38.3	57.2	144	121	0	34	32	34
2025	4	11	21	22	55	0.781	-0.089	3.691	0.013	0.01	0	47.7	38.3	75.3	144	121	0	33	32	33
2025	4	11	21	32	55	0.771	-0.092	3.691	0.016	0.013	0	48.2	38.7	68.4	145	122	0	33	32	34
2025	4	11	21	42	55	0.748	-0.092	3.691	0.01	0.007	0	46.9	38.3	69.7	143	121	0	34	32	33
2025	4	11	21	52	55	0.787	-0.075	3.691	0.01	0.007	0	46.9	37.8	74.8	143	120	0	34	32	33
2025	4	11	22	2	55	0.781	-0.066	3.691	0.016	0.013	0	47.7	38.7	74.4	144	122	0	33	32	33
2025	4	11	22	12	55	0.784	-0.069	3.694	0.013	0.01	0	47.3	38.3	75.3	144	121	0	34	32	33
2025	4	11	22	22	55	0.794	-0.085	3.694	0.013	0.01	0	48.2	38.3	74.4	145	121	0	33	32	33
2025	4	11	22	32	55	0.751	-0.102	3.694	0.013	0.01	0	48.2	38.7	74.4	145	122	0	33	32	33
2025	4	11	22	42	55	0.804	-0.075	3.694	0.013	0.01	0	47.7	37.8	73.5	145	121	0	34	33	34
2025	4	11	22	52	55	0.755	-0.056	3.694	0.013	0.01	0	47.7	37.4	73.5	144	120	0	33	33	33
2025	4	11	23	2	55	0.804	-0.082	3.694	0.01	0.007	0	47.3	37.8	72.2	144	120	0	34	32	34
2025	4	11	23	12	55	0.774	-0.105	3.694	0.01	0.007	0	47.3	37.8	72.7	144	120	0	34	32	33
2025	4	11	23	22	55	0.804	-0.115	3.698	0.013	0.01	0	47.7	37.8	70.5	145	121	0	34	33	34
2025	4	11	23	32	55	0.758	-0.095	3.701	0.016	0.016	0	47.7	38.3	71.4	145	121	0	34	32	34
2025	4	11	23	42	55	0.778	-0.062	3.704	0.01	0.007	0	47.7	38.7	72.7	145	122	0	34	32	33
2025	4	11	23	52	55	0.807	-0.089	3.707	0.016	0.013	0	47.7	37.8	71	145	121	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	12	0	2	55	0.764	-0.098	3.707	0.016	0.013	0	47.7	38.7	72.2	145	122	0	34	32	34
2025	4	12	0	12	55	0.784	-0.095	3.707	0.013	0.01	0	47.3	37.8	73.1	144	121	0	34	33	33
2025	4	12	0	22	55	0.758	-0.079	3.711	0.01	0.007	0	47.7	38.3	74	144	121	0	33	32	33
2025	4	12	0	32	55	0.791	-0.089	3.711	0.013	0.01	0	46.9	37.8	74	143	121	0	34	33	33
2025	4	12	0	42	55	0.797	-0.098	3.711	0.01	0.007	0	46.4	37.8	74.8	142	120	0	34	32	33
2025	4	12	0	52	55	0.732	-0.098	3.711	0.013	0.01	0	46.9	37.8	74	143	121	0	34	33	34
2025	4	12	1	2	55	0.755	-0.066	3.714	0.01	0.007	0	47.3	38.3	74.4	144	121	0	34	32	34
2025	4	12	1	12	55	0.823	-0.125	3.714	0.013	0.01	0	47.3	37.8	75.7	144	121	0	34	33	34
2025	4	12	1	22	55	0.817	-0.079	3.714	0.016	0.013	0	47.3	38.3	75.7	144	121	0	34	32	34
2025	4	12	1	32	55	0.797	-0.098	3.714	0.013	0.01	0	47.7	38.3	75.7	144	121	0	33	32	33
2025	4	12	1	42	55	0.86	-0.089	3.714	0.01	0.007	0	46.9	37.4	75.7	143	120	0	34	33	34
2025	4	12	1	52	55	0.787	-0.089	3.717	0.016	0.013	0	47.3	37.8	75.7	144	121	0	34	33	34
2025	4	12	2	2	55	0.758	-0.105	3.717	0.013	0.01	0	46.9	37.8	76.5	143	120	0	34	32	33
2025	4	12	2	12	55	0.814	-0.066	3.717	0.013	0.01	0	46.9	37.4	76.5	143	120	0	34	33	33
2025	4	12	2	22	55	0.778	-0.069	3.717	0.01	0.007	0	47.3	38.3	75.7	144	121	0	34	32	34
2025	4	12	2	32	55	0.774	-0.089	3.717	0.016	0.013	0	46.9	37.4	75.7	143	120	0	34	33	33
2025	4	12	2	42	55	0.801	-0.105	3.717	0.013	0.01	0	46.9	37.4	77	143	119	0	34	32	33
2025	4	12	2	52	55	0.778	-0.089	3.717	0.01	0.007	0	46.4	37	75.7	142	119	0	34	33	33
2025	4	12	3	2	55	0.784	-0.102	3.717	0.016	0.013	0	46.9	37.4	75.3	143	119	0	34	32	33
2025	4	12	3	12	55	0.784	-0.079	3.717	0.016	0.013	0	46.4	37	74.8	142	119	0	34	33	33
2025	4	12	3	22	55	0.784	-0.089	3.72	0.01	0.007	0	46.9	37.4	74.8	143	120	0	34	33	33
2025	4	12	3	32	55	0.778	-0.079	3.72	0.013	0.01	0	47.7	37.8	74.4	144	121	0	33	33	33
2025	4	12	3	42	55	0.797	-0.108	3.72	0.01	0.007	0	46.9	37	75.3	143	119	0	34	33	34
2025	4	12	3	52	55	0.814	-0.112	3.72	0.01	0.007	0	46.9	37.8	74.8	143	120	0	34	32	34
2025	4	12	4	2	55	0.794	-0.089	3.724	0.013	0.01	0	46.9	37.8	74.8	143	120	0	34	32	34
2025	4	12	4	12	55	0.797	-0.098	3.72	0.016	0.013	0	46.4	37.4	74.4	142	120	0	34	33	34
2025	4	12	4	22	55	0.787	-0.082	3.72	0.01	0.007	0	46.9	37.4	73.5	143	120	0	34	33	34
2025	4	12	4	32	55	0.84	-0.072	3.724	0.01	0.007	0	46.9	37.4	74	143	120	0	34	33	33
2025	4	12	4	42	55	0.797	-0.089	3.724	0.013	0.01	0	46.9	38.3	73.5	143	121	0	34	32	33
2025	4	12	4	52	55	0.771	-0.069	3.724	0.013	0.01	0	46.9	37.4	73.1	143	120	0	34	33	34
2025	4	12	5	2	55	0.791	-0.115	3.724	0.016	0.013	0	46.9	37.8	73.1	143	120	0	34	32	33
2025	4	12	5	12	55	0.778	-0.075	3.724	0.01	0.007	0	46	37.4	73.5	141	119	0	34	32	34
2025	4	12	5	22	55	0.787	-0.098	3.724	0.013	0.01	0	45.6	36.5	73.1	140	118	0	34	33	33
2025	4	12	5	32	55	0.801	-0.089	3.727	0.016	0.013	0	45.6	37	73.1	140	118	0	34	32	34
2025	4	12	5	42	55	0.814	-0.121	3.727	0.013	0.01	0	45.2	36.5	74	139	118	0	34	33	33
2025	4	12	5	52	55	0.823	-0.092	3.727	0.013	0.01	0	45.2	36.1	73.5	139	117	0	34	33	33
2025	4	12	6	2	55	0.791	-0.072	3.727	0.013	0.01	0	44.7	35.7	72.2	138	116	0	34	33	34
2025	4	12	6	12	55	0.794	-0.089	3.727	0.01	0.007	0	44.3	35.3	71.8	137	115	0	34	33	34
2025	4	12	6	22	55	0.774	-0.108	3.727	0.013	0.01	0	44.3	35.3	73.1	137	115	0	34	33	33
2025	4	12	6	32	55	0.794	-0.135	3.727	0.01	0.007	0	43.4	34.8	72.7	135	114	0	34	33	34
2025	4	12	6	42	55	0.787	-0.102	3.73	0.016	0.013	0	44.3	35.7	72.7	137	115	0	34	32	33
2025	4	12	6	52	55	0.817	-0.082	3.73	0.01	0.007	0	43.9	35.3	72.7	136	115	0	34	33	33
2025	4	12	7	2	55	0.758	-0.072	3.734	0.01	0.007	0	43.9	35.3	72.7	136	115	0	34	33	33
2025	4	12	7	12	55	0.751	-0.092	3.734	0.01	0.007	0	43.9	35.7	72.7	136	115	0	34	32	33
2025	4	12	7	22	55	0.764	-0.089	3.734	0.016	0.016	0	43.9	35.3	72.2	137	115	0	35	33	34
2025	4	12	7	32	55	0.781	-0.066	3.734	0.013	0.01	0	43.9	35.3	72.7	136	115	0	34	33	33
2025	4	12	7	42	55	0.82	-0.102	3.737	0.013	0.01	0	44.3	36.1	72.2	137	116	0	34	32	34
2025	4	12	7	52	55	0.787	-0.089	3.734	0.016	0.013	0	44.3	35.3	72.2	137	115	0	34	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	12	8	2	55	0.81	-0.105	3.737	0.01	0.007	0	44.3	35.7	73.1	137	115	0	34	32	33
2025	4	12	8	12	55	0.84	-0.092	3.74	0.013	0.01	0	44.7	37	73.5	138	118	0	34	32	33
2025	4	12	8	22	55	0.804	-0.105	3.74	0.01	0.007	0	44.3	35.7	73.1	137	116	0	34	33	34
2025	4	12	8	32	55	0.797	-0.098	3.74	0.01	0.007	0	44.3	36.5	73.5	137	117	0	34	32	34
2025	4	12	8	42	55	0.791	-0.082	3.74	0.013	0.01	0	44.3	35.7	74	137	117	0	34	34	33
2025	4	12	8	52	55	0.774	-0.108	3.74	0.013	0.01	0	44.3	35.7	73.1	137	116	0	34	33	33
2025	4	12	9	2	55	0.791	-0.089	3.74	0.013	0.01	0	44.7	35.7	68.4	137	116	0	33	33	33
2025	4	12	9	12	55	0.81	-0.098	3.74	0.013	0.01	0	44.3	36.1	62.4	137	116	0	34	32	34
2025	4	12	9	22	55	0.801	-0.102	3.737	0.013	0.01	0	44.7	36.1	59.3	137	117	0	33	33	34
2025	4	12	9	32	55	0.814	-0.082	3.737	0.01	0.007	0	44.3	36.1	47.3	137	117	0	34	33	34
2025	4	12	9	42	55	0.764	-0.102	3.737	0.013	0.01	0	44.3	36.1	59.8	137	116	0	34	32	34
2025	4	12	9	52	55	0.804	-0.089	3.743	0.016	0.013	0	44.7	35.7	74.4	137	116	0	33	33	33
2025	4	12	10	2	55	0.774	-0.112	3.74	0.013	0.01	0	43.9	36.5	49.9	137	117	0	35	32	33
2025	4	12	10	12	55	0.794	-0.082	3.74	0.016	0.013	0	44.3	36.1	54.6	137	117	0	34	33	33
2025	4	12	10	22	55	0.794	-0.105	3.74	0.016	0.013	0	44.7	36.1	61.9	137	117	0	33	33	34
2025	4	12	10	32	55	0.741	-0.085	3.74	0.016	0.013	0	44.3	36.5	49.5	137	117	0	34	32	34
2025	4	12	10	42	55	0.778	-0.072	3.74	0.013	0.01	0	44.3	35.7	51.6	137	116	0	34	33	33
2025	4	12	10	52	55	0.781	-0.075	3.743	0.01	0.007	0	44.3	36.1	46.9	136	116	0	33	32	33
2025	4	12	11	2	55	0.771	-0.079	3.743	0.01	0.007	0	44.3	36.1	46.4	136	116	0	33	32	34
2025	4	12	11	12	55	0.745	-0.105	3.74	0.013	0.01	0	44.3	35.7	52.9	137	116	0	34	33	32
2025	4	12	11	22	55	0.787	-0.121	3.743	0.01	0.007	0	44.3	36.5	59.8	137	117	0	34	32	33
2025	4	12	11	32	55	0.748	-0.062	3.743	0.013	0.01	0	44.3	36.1	48.6	137	116	0	34	32	33
2025	4	12	11	42	55	0.787	-0.062	3.743	0.016	0.013	0	45.2	36.1	58	138	117	0	33	33	33
2025	4	12	11	52	55	0.768	-0.089	3.747	0.01	0.007	0	44.3	36.5	47.3	137	117	0	34	32	33
2025	4	12	12	2	55	0.751	-0.049	3.743	0.016	0.016	0	44.7	36.5	47.3	138	117	0	34	32	33
2025	4	12	12	12	55	0.787	-0.089	3.743	0.016	0.013	0	44.3	36.1	46	137	116	0	34	32	33
2025	4	12	12	22	55	0.748	-0.085	3.743	0.013	0.01	0	44.7	36.1	52	138	117	0	34	33	33
2025	4	12	12	32	55	0.794	-0.089	3.743	0.01	0.007	0	44.3	36.5	49	137	117	0	34	32	33
2025	4	12	12	42	55	0.791	-0.092	3.747	0.013	0.01	0	44.7	36.1	46.9	137	117	0	33	33	33
2025	4	12	12	52	55	0.787	-0.092	3.747	0.016	0.013	0	44.7	36.5	55	138	117	0	34	32	33
2025	4	12	13	2	55	0.774	-0.095	3.747	0.01	0.007	0	44.7	36.1	50.3	137	116	0	33	32	33
2025	4	12	13	12	55	0.764	-0.112	3.747	0.01	0.007	0	45.6	37.8	47.7	140	120	0	34	32	32
2025	4	12	13	22	55	0.771	-0.075	3.747	0.013	0.01	0	44.7	36.5	61.1	138	117	0	34	32	33
2025	4	12	13	32	55	0.787	-0.095	3.75	0.016	0.013	0	44.3	36.5	58	137	117	0	34	32	33
2025	4	12	13	42	55	0.791	-0.105	3.747	0.013	0.01	0	44.7	36.5	73.5	137	117	0	33	32	34
2025	4	12	13	52	55	0.804	-0.128	3.747	0.013	0.01	0	44.7	36.1	63.6	137	117	0	33	33	33
2025	4	12	14	2	55	0.781	-0.095	3.75	0.01	0.007	0	45.2	36.5	73.1	138	117	0	33	32	34
2025	4	12	14	12	55	0.768	-0.082	3.747	0.013	0.01	0	44.7	36.5	46.9	137	117	0	33	32	32
2025	4	12	14	22	55	0.758	-0.039	3.75	0.013	0.01	0	45.2	37	59.3	139	118	0	34	32	33
2025	4	12	14	32	55	0.82	-0.105	3.75	0.01	0.007	0	45.2	36.5	57.2	138	117	0	33	32	33
2025	4	12	14	42	55	0.82	-0.062	3.753	0.016	0.013	0	45.2	36.5	71.8	138	117	0	33	32	33
2025	4	12	14	52	55	0.781	-0.092	3.75	0.016	0.013	0	44.7	37	66.2	138	118	0	34	32	33
2025	4	12	15	2	55	0.801	-0.092	3.75	0.013	0.01	0	46	36.5	61.1	141	117	0	34	32	33
2025	4	12	15	12	55	0.814	-0.089	3.753	0.01	0.007	0	46.4	37	68.8	141	118	0	33	32	33
2025	4	12	15	22	55	0.833	-0.092	3.753	0.01	0.007	0	46	37	62.4	141	118	0	34	32	33
2025	4	12	15	32	55	0.787	-0.095	3.753	0.013	0.01	0	46	36.5	66.7	141	117	0	34	32	33
2025	4	12	15	42	55	0.787	-0.069	3.753	0.01	0.007	0	46.4	36.1	68.8	141	117	0	33	33	33
2025	4	12	15	52	55	0.801	-0.059	3.753	0.013	0.01	0	46	36.1	73.1	141	116	0	34	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	12	16	2	55	0.804	-0.118	3.753	0.01	0.007	0	45.6	35.7	72.2	140	115	0	34	32	33
2025	4	12	16	12	55	0.781	-0.069	3.753	0.01	0.007	0	45.6	35.7	71.8	140	115	0	34	32	33
2025	4	12	16	22	55	0.817	-0.082	3.757	0.01	0.007	0	45.6	35.7	72.7	140	115	0	34	32	32
2025	4	12	16	32	55	0.83	-0.095	3.757	0.01	0.007	0	46	36.1	72.7	141	116	0	34	32	33
2025	4	12	16	42	55	0.794	-0.046	3.757	0.013	0.01	0	46.4	37.4	60.2	142	119	0	34	32	33
2025	4	12	16	52	55	0.787	-0.079	3.757	0.01	0.007	0	46.9	37	57.2	142	118	0	33	32	33
2025	4	12	17	2	55	0.82	-0.085	3.76	0.013	0.01	0	46.9	37	71.8	143	118	0	34	32	32
2025	4	12	17	12	55	0.833	-0.092	3.753	0.013	0.01	0	46.9	37	50.7	142	119	0	33	33	34
2025	4	12	17	22	55	0.801	-0.098	3.757	0.013	0.01	0	46.9	37.8	49.5	143	119	0	34	31	32
2025	4	12	17	32	55	0.84	-0.092	3.76	0.016	0.013	0	47.3	37.4	72.2	143	119	0	33	32	33
2025	4	12	17	42	55	0.778	-0.092	3.76	0.01	0.007	0	46.9	37.4	68.8	142	119	0	33	32	33
2025	4	12	17	52	55	0.791	-0.095	3.76	0.01	0.007	0	46.9	37.4	67.9	143	119	0	34	32	33
2025	4	12	18	2	55	0.82	-0.095	3.76	0.01	0.007	0	47.3	37	66.7	143	119	0	33	33	34
2025	4	12	18	12	55	0.794	-0.075	3.763	0.013	0.01	0	47.3	37.4	74	144	120	0	34	33	33
2025	4	12	18	22	55	0.81	-0.082	3.763	0.013	0.01	0	47.7	37.8	74.8	144	120	0	33	32	33
2025	4	12	18	32	55	0.83	-0.095	3.763	0.01	0.007	0	47.3	37.8	75.3	144	121	0	34	33	33
2025	4	12	18	42	55	0.823	-0.079	3.766	0.013	0.01	0	48.2	38.3	74.8	145	121	0	33	32	33
2025	4	12	18	52	55	0.814	-0.075	3.766	0.01	0.007	0	48.6	38.7	77	146	122	0	33	32	32
2025	4	12	19	2	55	0.814	-0.112	3.763	0.013	0.01	0	48.6	38.7	75.7	146	122	0	33	32	33
2025	4	12	19	12	55	0.771	-0.092	3.763	0.016	0.016	0	48.6	39.1	71.8	146	122	0	33	31	33
2025	4	12	19	22	55	0.84	-0.105	3.766	0.013	0.01	0	48.2	37.8	76.5	145	121	0	33	33	33
2025	4	12	19	32	55	0.814	-0.075	3.766	0.01	0.007	0	48.6	38.3	74.8	146	122	0	33	33	34
2025	4	12	19	42	55	0.82	-0.108	3.766	0.016	0.013	0	48.6	38.7	76.1	146	122	0	33	32	33
2025	4	12	19	52	55	0.84	-0.102	3.766	0.013	0.01	0	48.2	38.7	76.5	146	122	0	34	32	34
2025	4	12	20	2	55	0.843	-0.115	3.766	0.013	0.01	0	48.6	38.3	76.1	146	122	0	33	33	32
2025	4	12	20	12	55	0.778	-0.089	3.766	0.01	0.007	0	48.2	38.7	75.7	146	122	0	34	32	33
2025	4	12	20	22	55	0.784	-0.085	3.763	0.01	0.007	0	48.2	38.7	61.5	146	122	0	34	32	33
2025	4	12	20	32	55	0.768	-0.105	3.763	0.016	0.013	0	47.7	38.3	47.3	145	121	0	34	32	34
2025	4	12	20	42	55	0.794	-0.066	3.763	0.013	0.01	0	47.7	38.3	76.1	145	121	0	34	32	33
2025	4	12	20	52	55	0.83	-0.079	3.763	0.01	0.007	0	48.2	38.3	76.1	146	121	0	34	32	33
2025	4	12	21	2	55	0.843	-0.089	3.763	0.01	0.007	0	47.7	37.8	76.1	145	121	0	34	33	33
2025	4	12	21	12	55	0.807	-0.069	3.763	0.013	0.01	0	48.2	38.7	76.1	146	122	0	34	32	33
2025	4	12	21	22	55	0.817	-0.102	3.763	0.016	0.013	0	48.6	38.3	75.7	146	121	0	33	32	33
2025	4	12	21	32	55	0.778	-0.049	3.763	0.01	0.007	0	48.6	38.7	71.8	146	122	0	33	32	34
2025	4	12	21	42	55	0.833	-0.102	3.763	0.013	0.01	0	48.6	37.8	73.5	146	121	0	33	33	34
2025	4	12	21	52	55	0.804	-0.089	3.763	0.013	0.01	0	48.2	38.3	67.9	146	121	0	34	32	33
2025	4	12	22	2	55	0.823	-0.075	3.763	0.016	0.013	0	48.2	38.3	71.4	146	121	0	34	32	33
2025	4	12	22	12	55	0.781	-0.092	3.763	0.013	0.01	0	48.2	37.8	73.5	146	121	0	34	33	33
2025	4	12	22	22	55	0.764	-0.039	3.763	0.01	0.007	0	48.2	36.5	74.4	146	117	0	34	32	33
2025	4	12	22	32	55	0.784	-0.052	3.763	0.013	0.01	0	48.2	37.8	75.7	145	121	0	33	33	33
2025	4	12	22	42	55	0.791	-0.098	3.766	0.016	0.013	0	47.7	37.8	76.1	145	121	0	34	33	33
2025	4	12	22	52	55	0.823	-0.066	3.766	0.01	0.007	0	47.7	37.4	76.1	145	120	0	34	33	33
2025	4	12	23	2	55	0.784	-0.079	3.766	0.01	0.007	0	47.7	37.4	76.1	145	120	0	34	33	33
2025	4	12	23	12	55	0.817	-0.128	3.766	0.013	0.01	0	47.3	37.8	75.7	144	120	0	34	32	34
2025	4	12	23	22	55	0.814	-0.105	3.766	0.016	0.013	0	47.7	37.8	75.7	145	121	0	34	33	33
2025	4	12	23	32	55	0.794	-0.069	3.763	0.013	0.01	0	47.3	37.8	75.3	144	121	0	34	33	34
2025	4	12	23	42	55	0.827	-0.089	3.763	0.01	0.007	0	47.3	37.8	74.8	144	120	0	34	32	33
2025	4	12	23	52	55	0.794	-0.085	3.763	0.013	0.01	0	47.3	37.4	74.8	144	120	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	13	0	2	55	0.807	-0.075	3.763	0.016	0.013	0	47.3	37.4	74.8	144	120	0	34	33	34
2025	4	13	0	12	55	0.85	-0.085	3.763	0.013	0.01	0	47.3	37.4	74.8	144	120	0	34	33	33
2025	4	13	0	22	55	0.833	-0.082	3.763	0.013	0.01	0	47.7	37.4	74	144	120	0	33	33	33
2025	4	13	0	32	55	0.85	-0.098	3.763	0.01	0.007	0	47.3	37.4	74.8	144	119	0	34	32	33
2025	4	13	0	42	55	0.768	-0.112	3.763	0.013	0.01	0	47.3	37.8	74.8	144	120	0	34	32	33
2025	4	13	0	52	55	0.84	-0.102	3.766	0.01	0.007	0	47.3	37.8	74.8	144	120	0	34	32	33
2025	4	13	1	2	55	0.81	-0.112	3.766	0.016	0.013	0	47.3	37.8	74.8	144	120	0	34	32	33
2025	4	13	1	12	55	0.804	-0.089	3.763	0.01	0.007	0	47.3	37.4	73.1	144	120	0	34	33	34
2025	4	13	1	22	55	0.791	-0.072	3.766	0.013	0.01	0	47.3	37.4	73.5	144	120	0	34	33	33
2025	4	13	1	32	55	0.814	-0.089	3.766	0.01	0.007	0	47.3	37.4	72.2	144	120	0	34	33	33
2025	4	13	1	42	55	0.807	-0.105	3.766	0.013	0.01	0	47.3	37.4	71.4	144	120	0	34	33	34
2025	4	13	1	52	55	0.82	-0.092	3.766	0.016	0.013	0	47.7	38.3	68.8	145	121	0	34	32	33
2025	4	13	2	2	55	0.804	-0.089	3.763	0.016	0.013	0	47.3	37.4	59.8	144	120	0	34	33	34
2025	4	13	2	12	55	0.787	-0.108	3.763	0.016	0.013	0	47.3	37.8	58.9	144	120	0	34	32	34
2025	4	13	2	22	55	0.82	-0.059	3.763	0.013	0.01	0	48.2	37.8	55.9	145	121	0	33	33	33
2025	4	13	2	32	55	0.758	-0.112	3.763	0.016	0.013	0	48.2	38.7	52.5	146	122	0	34	32	34
2025	4	13	2	42	55	0.837	-0.128	3.763	0.01	0.007	0	47.3	37.8	53.8	144	120	0	34	32	34
2025	4	13	2	52	55	0.768	-0.102	3.763	0.016	0.013	0	48.2	38.3	55.5	146	122	0	34	33	34
2025	4	13	3	2	55	0.801	-0.102	3.766	0.01	0.007	0	47.7	37.4	63.6	145	120	0	34	33	33
2025	4	13	3	12	55	0.82	-0.079	3.763	0.013	0.01	0	47.7	37.4	55.5	144	120	0	33	33	33
2025	4	13	3	22	55	0.801	-0.079	3.763	0.01	0.007	0	47.3	37.8	54.6	144	121	0	34	33	33
2025	4	13	3	32	55	0.787	-0.066	3.763	0.013	0.01	0	47.7	37.8	53.8	145	121	0	34	33	33
2025	4	13	3	42	55	0.771	-0.072	3.763	0.01	0.007	0	47.7	37.8	50.3	145	121	0	34	33	33
2025	4	13	3	52	55	0.771	-0.075	3.763	0.013	0.01	0	47.7	37.8	52.5	145	121	0	34	33	33
2025	4	13	4	2	55	0.856	-0.082	3.763	0.013	0.01	0	47.7	38.3	52.9	145	121	0	34	32	34
2025	4	13	4	12	55	0.774	-0.046	3.763	0.01	0.007	0	49	38.7	53.8	147	122	0	33	32	34
2025	4	13	4	22	55	0.797	-0.072	3.763	0.01	0.007	0	48.6	38.7	53.8	147	122	0	34	32	33
2025	4	13	4	32	55	0.823	-0.089	3.766	0.013	0.01	0	48.2	38.3	55.9	146	122	0	34	33	33
2025	4	13	4	42	55	0.846	-0.082	3.766	0.013	0.01	0	48.2	37.4	55.9	146	121	0	34	34	34
2025	4	13	4	52	55	0.761	-0.059	3.766	0.013	0.01	0	48.2	38.3	51.6	147	122	0	35	33	32
2025	4	13	5	2	55	0.758	-0.069	3.766	0.013	0.01	0	48.2	38.3	53.8	146	121	0	34	32	34
2025	4	13	5	12	55	0.778	-0.121	3.766	0.013	0.01	0	48.2	37.8	55.9	146	121	0	34	33	34
2025	4	13	5	22	55	0.81	-0.095	3.766	0.013	0.01	0	48.6	37.8	57.6	147	121	0	34	33	33
2025	4	13	5	32	55	0.804	-0.079	3.77	0.01	0.007	0	48.2	37.8	65.4	146	121	0	34	33	34
2025	4	13	5	42	55	0.791	-0.089	3.77	0.013	0.01	0	48.2	38.3	71.8	146	121	0	34	32	34
2025	4	13	5	52	55	0.768	-0.095	3.77	0.013	0.01	0	47.7	37.4	73.1	145	120	0	34	33	33
2025	4	13	6	2	55	0.787	-0.089	3.77	0.013	0.01	0	47.7	37.8	72.7	145	120	0	34	32	33
2025	4	13	6	12	55	0.81	-0.095	3.77	0.016	0.016	0	46.9	37	72.7	143	118	0	34	32	33
2025	4	13	6	22	55	0.804	-0.066	3.77	0.013	0.01	0	46.9	37	73.1	143	118	0	34	32	33
2025	4	13	6	32	55	0.823	-0.072	3.773	0.01	0.007	0	46.9	37	72.2	143	118	0	34	32	33
2025	4	13	6	42	55	0.794	-0.052	3.77	0.013	0.01	0	46.4	36.1	53.3	142	117	0	34	33	33
2025	4	13	6	52	55	0.837	-0.108	3.773	0.01	0.007	0	46.4	36.1	48.6	142	117	0	34	33	33
2025	4	13	7	2	55	0.83	-0.102	3.773	0.013	0.01	0	46	36.5	49	141	117	0	34	32	33
2025	4	13	7	12	55	0.778	-0.102	3.77	0.01	0.007	0	46.4	36.5	48.6	142	118	0	34	33	33
2025	4	13	7	22	55	0.764	-0.082	3.776	0.013	0.01	0	46	36.5	48.2	141	118	0	34	33	33
2025	4	13	7	32	55	0.778	-0.069	3.773	0.01	0.007	0	46.4	37	46.4	142	118	0	34	32	34
2025	4	13	7	42	55	0.833	-0.095	3.773	0.01	0.007	0	46	36.5	46.9	141	117	0	34	32	33
2025	4	13	7	52	55	0.768	-0.052	3.773	0.01	0.007	0	47.3	37	47.3	143	119	0	33	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	13	8	2	55	0.758	-0.075	3.77	0.01	0.007	0	47.3	37.8	46.4	144	120	0	34	32	33
2025	4	13	8	12	55	0.81	-0.062	3.773	0.01	0.007	0	47.3	37.4	46.9	143	120	0	33	33	33
2025	4	13	8	22	55	0.768	-0.062	3.773	0.01	0.007	0	47.3	37.8	46.4	143	120	0	33	32	33
2025	4	13	8	32	55	0.755	-0.082	3.77	0.013	0.01	0	46.9	37.4	46.9	143	120	0	34	33	33
2025	4	13	8	42	55	0.768	-0.092	3.773	0.013	0.01	0	47.3	37.4	46.4	144	120	0	34	33	34
2025	4	13	8	52	55	0.751	-0.062	3.77	0.01	0.007	0	47.3	37.8	46.4	144	120	0	34	32	34
2025	4	13	9	2	55	0.781	-0.075	3.773	0.01	0.007	0	47.3	37.4	44.7	144	120	0	34	33	33
2025	4	13	9	12	55	0.807	-0.089	3.773	0.01	0.007	0	46.9	35.3	46.9	143	114	0	34	32	34
2025	4	13	9	22	55	0.804	-0.098	3.773	0.016	0.016	0	46.9	37.4	47.3	143	119	0	34	32	33
2025	4	13	9	32	55	0.82	-0.105	3.773	0.016	0.013	0	46.4	37	48.2	142	119	0	34	33	33
2025	4	13	9	42	55	0.778	-0.049	3.773	0.016	0.013	0	46.9	37.8	48.6	143	120	0	34	32	33
2025	4	13	9	52	55	0.781	-0.082	3.773	0.016	0.013	0	46.9	37.4	47.3	143	119	0	34	32	33
2025	4	13	10	2	55	0.823	-0.095	3.773	0.01	0.007	0	46.9	37.8	47.7	142	119	0	33	31	33
2025	4	13	10	12	55	0.814	-0.089	3.776	0.01	0.007	0	46.4	36.5	46.9	142	118	0	34	33	34
2025	4	13	10	22	55	0.791	-0.079	3.773	0.01	0.007	0	46.9	37.4	48.6	143	119	0	34	32	34
2025	4	13	10	32	55	0.817	-0.069	3.773	0.01	0.007	0	46.4	37	49	142	118	0	34	32	34
2025	4	13	10	42	55	0.801	-0.059	3.773	0.013	0.01	0	46	36.5	50.3	141	117	0	34	32	33
2025	4	13	10	52	55	0.83	-0.089	3.776	0.013	0.01	0	46	36.5	49.5	141	117	0	34	32	34
2025	4	13	11	2	55	0.771	-0.089	3.773	0.01	0.007	0	46.4	36.5	50.3	141	117	0	33	32	34
2025	4	13	11	12	55	0.787	-0.089	3.773	0.013	0.01	0	46.9	37	50.3	142	118	0	33	32	34
2025	4	13	11	22	55	0.804	-0.089	3.773	0.013	0.01	0	45.6	36.1	52	140	116	0	34	32	33
2025	4	13	11	32	55	0.764	-0.085	3.773	0.01	0.007	0	46	36.1	54.6	140	117	0	33	33	33
2025	4	13	11	42	55	0.787	-0.069	3.773	0.013	0.01	0	45.6	36.1	53.8	140	116	0	34	32	33
2025	4	13	11	52	55	0.771	-0.075	3.773	0.013	0.01	0	45.6	36.1	59.3	140	116	0	34	32	33
2025	4	13	12	2	55	0.758	-0.095	3.776	0.013	0.01	0	45.2	36.1	64.9	140	117	0	35	33	33
2025	4	13	12	12	55	0.784	-0.082	3.776	0.01	0.007	0	45.6	36.5	56.3	140	117	0	34	32	33
2025	4	13	12	22	55	0.807	-0.075	3.776	0.01	0.007	0	46	36.5	72.7	141	117	0	34	32	33
2025	4	13	12	32	55	0.82	-0.102	3.776	0.016	0.013	0	45.2	36.1	65.4	140	116	0	35	32	33
2025	4	13	12	42	55	0.797	-0.108	3.776	0.013	0.01	0	46	36.1	71.8	140	117	0	33	33	33
2025	4	13	12	52	55	0.774	-0.066	3.776	0.01	0.007	0	46	37	74.4	140	117	0	33	31	34
2025	4	13	13	2	55	0.768	-0.098	3.776	0.01	0.007	0	46	36.5	71.8	141	117	0	34	32	33
2025	4	13	13	12	55	0.791	-0.056	3.776	0.016	0.013	0	46.9	36.5	65.4	142	118	0	33	33	33
2025	4	13	13	22	55	0.755	-0.075	3.776	0.013	0.01	0	46	36.5	65.8	141	117	0	34	32	33
2025	4	13	13	32	55	0.82	-0.092	3.776	0.016	0.013	0	46	36.1	72.7	141	117	0	34	33	33
2025	4	13	13	42	55	0.787	-0.125	3.776	0.016	0.013	0	45.6	36.5	74.8	140	117	0	34	32	33
2025	4	13	13	52	55	0.778	-0.049	3.776	0.013	0.01	0	46.4	36.1	73.1	141	117	0	33	33	33
2025	4	13	14	2	55	0.82	-0.105	3.776	0.013	0.01	0	46	37	74.4	141	118	0	34	32	33
2025	4	13	14	12	55	0.791	-0.089	3.78	0.01	0.007	0	46	36.5	74.4	141	117	0	34	32	33
2025	4	13	14	22	55	0.794	-0.098	3.78	0.01	0.007	0	46.4	36.1	74	141	117	0	33	33	33
2025	4	13	14	32	55	0.791	-0.072	3.776	0.01	0.007	0	46.4	37	72.7	141	118	0	33	32	33
2025	4	13	14	42	55	0.833	-0.072	3.78	0.01	0.007	0	46	36.5	76.1	140	117	0	33	32	33
2025	4	13	14	52	55	0.778	-0.092	3.78	0.013	0.01	0	46.4	36.5	75.3	141	118	0	33	33	34
2025	4	13	15	2	55	0.81	-0.059	3.78	0.013	0.01	0	46.9	36.5	75.7	142	118	0	33	33	33
2025	4	13	15	12	55	0.797	-0.092	3.78	0.013	0.01	0	46.9	37	76.5	142	118	0	33	32	33
2025	4	13	15	22	55	0.817	-0.105	3.78	0.013	0.01	0	46	36.5	74.8	141	118	0	34	33	34
2025	4	13	15	32	55	0.843	-0.066	3.78	0.013	0.01	0	46.4	37	76.1	142	118	0	34	32	33
2025	4	13	15	42	55	0.85	-0.082	3.78	0.01	0.007	0	46.4	37	75.3	141	118	0	33	32	33
2025	4	13	15	52	55	0.814	-0.092	3.78	0.01	0.007	0	46	37	74.8	141	118	0	34	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	13	16	2	55	0.817	-0.072	3.78	0.01	0.007	0	46	36.5	75.3	141	118	0	34	33	33
2025	4	13	16	12	55	0.814	-0.092	3.78	0.013	0.01	0	46.9	37	75.7	142	118	0	33	32	33
2025	4	13	16	22	55	0.804	-0.102	3.78	0.01	0.007	0	46.4	37	74.8	142	118	0	34	32	33
2025	4	13	16	32	55	0.81	-0.105	3.78	0.01	0.007	0	46	37	75.3	141	118	0	34	32	33
2025	4	13	16	42	55	0.846	-0.069	3.78	0.01	0.007	0	46.9	37	74.8	142	118	0	33	32	33
2025	4	13	16	52	55	0.791	-0.049	3.78	0.013	0.01	0	46	37	74.8	141	118	0	34	32	33
2025	4	13	17	2	55	0.833	-0.115	3.78	0.013	0.01	0	46.9	37.4	74.8	142	119	0	33	32	34
2025	4	13	17	12	55	0.846	-0.105	3.78	0.016	0.013	0	45.6	35.7	75.7	140	116	0	34	33	33
2025	4	13	17	22	55	0.833	-0.089	3.78	0.013	0.01	0	46	36.1	74.4	140	117	0	33	33	34
2025	4	13	17	32	55	0.794	-0.105	3.78	0.013	0.01	0	46	36.5	75.3	141	117	0	34	32	33
2025	4	13	17	42	55	0.797	-0.085	3.78	0.013	0.01	0	46.4	36.5	74.8	141	117	0	33	32	33
2025	4	13	17	52	55	0.787	-0.066	3.78	0.016	0.013	0	46	37	74.4	141	118	0	34	32	33
2025	4	13	18	2	55	0.797	-0.075	3.78	0.01	0.007	0	46	37	74.4	141	118	0	34	32	33
2025	4	13	18	12	55	0.873	-0.105	3.78	0.01	0.007	0	46	37	74.4	141	118	0	34	32	33
2025	4	13	18	22	55	0.787	-0.089	3.78	0.01	0.007	0	46.4	37	74.4	142	118	0	34	32	33
2025	4	13	18	32	55	0.823	-0.079	3.78	0.01	0.007	0	46.4	36.5	74.4	142	118	0	34	33	33
2025	4	13	18	42	55	0.83	-0.108	3.78	0.016	0.013	0	46.9	36.5	74	142	118	0	33	33	33
2025	4	13	18	52	55	0.856	-0.072	3.78	0.01	0.007	0	47.3	37.4	72.7	143	119	0	33	32	33
2025	4	13	19	2	55	0.833	-0.085	3.78	0.016	0.013	0	47.3	37.4	73.1	144	120	0	34	33	33
2025	4	13	19	12	55	0.833	-0.059	3.78	0.013	0.01	0	47.7	37.8	73.1	144	120	0	33	32	33
2025	4	13	19	22	55	0.82	-0.089	3.783	0.013	0.01	0	47.3	37.8	73.1	144	120	0	34	32	33
2025	4	13	19	32	55	0.797	-0.105	3.783	0.013	0.01	0	47.7	37.8	73.1	144	120	0	33	32	34
2025	4	13	19	42	55	0.784	-0.079	3.786	0.013	0.01	0	47.3	37.4	73.5	144	120	0	34	33	34
2025	4	13	19	52	55	0.82	-0.066	3.789	0.01	0.007	0	48.2	37.8	74	145	120	0	33	32	33
2025	4	13	20	2	55	0.814	-0.115	3.789	0.016	0.013	0	46.9	37.4	74.4	143	119	0	34	32	33
2025	4	13	20	12	55	0.814	-0.108	3.789	0.016	0.013	0	46.9	37.4	74.8	143	119	0	34	32	33
2025	4	13	20	22	55	0.801	-0.105	3.789	0.01	0.007	0	46.9	37.4	74.8	143	119	0	34	32	33
2025	4	13	20	32	55	0.863	-0.092	3.789	0.01	0.007	0	46.9	37	75.3	143	119	0	34	33	33
2025	4	13	20	42	55	0.846	-0.098	3.789	0.013	0.01	0	46.9	37.8	74	143	119	0	34	31	34
2025	4	13	20	52	55	0.843	-0.095	3.789	0.02	0.016	0	46.9	37	74.4	143	118	0	34	32	34
2025	4	13	21	2	55	0.781	-0.082	3.789	0.013	0.01	0	46.9	36.5	74.8	142	118	0	33	33	34
2025	4	13	21	12	55	0.843	-0.112	3.789	0.016	0.013	0	46.4	36.5	75.7	142	118	0	34	33	33
2025	4	13	21	22	55	0.837	-0.059	3.789	0.016	0.013	0	46.4	36.5	75.3	142	118	0	34	33	34
2025	4	13	21	32	55	0.837	-0.112	3.789	0.01	0.007	0	46.9	36.5	76.5	142	118	0	33	33	33
2025	4	13	21	42	55	0.83	-0.059	3.789	0.01	0.007	0	46.9	36.5	77	142	118	0	33	33	33
2025	4	13	21	52	55	0.82	-0.062	3.793	0.013	0.01	0	46.9	37	76.5	142	118	0	33	32	33
2025	4	13	22	2	55	0.817	-0.075	3.789	0.013	0.01	0	46.4	37	76.1	142	118	0	34	32	34
2025	4	13	22	12	55	0.846	-0.108	3.789	0.01	0.007	0	46.4	36.5	77	142	118	0	34	33	34
2025	4	13	22	22	55	0.843	-0.102	3.789	0.013	0.01	0	47.3	37	76.1	143	119	0	33	33	33
2025	4	13	22	32	55	0.827	-0.089	3.789	0.013	0.01	0	46.9	37.8	75.3	143	120	0	34	32	34
2025	4	13	22	42	55	0.807	-0.089	3.789	0.013	0.01	0	47.3	37.4	76.1	144	120	0	34	33	33
2025	4	13	22	52	55	0.82	-0.075	3.789	0.013	0.01	0	46.9	37.4	75.3	143	120	0	34	33	34
2025	4	13	23	2	55	0.85	-0.131	3.789	0.013	0.01	0	46.9	37	76.1	143	119	0	34	33	33
2025	4	13	23	12	55	0.801	-0.095	3.789	0.01	0.007	0	47.3	37.4	76.1	143	120	0	33	33	33
2025	4	13	23	22	55	0.784	-0.079	3.789	0.016	0.013	0	46.9	37.8	76.5	143	120	0	34	32	34
2025	4	13	23	32	55	0.853	-0.118	3.789	0.01	0.007	0	46.9	37.4	77.8	143	120	0	34	33	33
2025	4	13	23	42	55	0.804	-0.105	3.789	0.013	0.01	0	46.9	37.4	77	143	119	0	34	32	33
2025	4	13	23	52	55	0.823	-0.089	3.789	0.013	0.01	0	46.9	37.8	76.5	143	120	0	34	32	34

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	4	14	0	2	55	0.801	-0.092	3.789	0.016	0.013	0	47.3	37.4	77	144	120	0	34	33	34	
2025	4	14	0	12	55	0.84	-0.098	3.789	0.013	0.01	0	46.9	37.4	77.8	143	120	0	34	33	33	
2025	4	14	0	22	55	0.843	-0.085	3.789	0.013	0.01	0	46.9	37.8	78.3	143	120	0	34	32	33	
2025	4	14	0	32	55	0.801	-0.085	3.789	0.01	0.007	0	47.3	37.4	78.7	143	119	0	33	32	33	
2025	4	14	0	42	55	0.817	-0.108	3.789	0.01	0.007	0	46.9	37	78.7	143	119	0	34	33	33	
2025	4	14	0	52	55	0.787	-0.079	3.793	0.013	0.01	0	47.3	37.4	77.8	144	120	0	34	33	33	
2025	4	14	1	2	55	0.761	-0.052	3.789	0.013	0.01	0	46.9	37.4	77.8	143	120	0	34	33	33	
2025	4	14	1	12	55	0.778	-0.069	3.789	0.013	0.01	0	46.9	37	77.8	143	119	0	34	33	33	
2025	4	14	1	22	55	0.807	-0.082	3.789	0.01	0.007	0	46.9	37.4	77.8	143	120	0	34	33	34	
2025	4	14	1	32	55	0.797	-0.098	3.793	0.013	0.01	0	46.9	37.4	79.1	143	120	0	34	33	34	
2025	4	14	1	42	55	0.764	-0.089	3.789	0.016	0.013	0	46.9	37.4	78.3	143	119	0	34	32	33	
2025	4	14	1	52	55	0.801	-0.125	3.793	0.01	0.007	0	46.4	37.4	77.8	142	119	0	34	32	34	
2025	4	14	2	2	55	0.83	-0.115	3.793	0.016	0.013	0	46.4	37	77.8	142	119	0	34	33	33	
2025	4	14	2	12	55	0.794	-0.102	3.793	0.016	0.013	0	46.9	37.8	77	143	120	0	34	32	33	
2025	4	14	2	22	55	0.814	-0.089	3.793	0.01	0.007	0	46.9	37.4	77.8	143	119	0	34	32	33	
2025	4	14	2	32	55	0.81	-0.089	3.793	0.016	0.013	0	46.9	37	78.3	143	119	0	34	33	33	
2025	4	14	2	42	55	0.817	-0.098	3.793	0.013	0.01	0	46.9	37.4	79.1	143	119	0	34	32	33	
2025	4	14	2	52	55	0.843	-0.085	3.793	0.013	0.01	0	46.4	37	77	143	119	0	35	33	33	
2025	4	14	3	2	55	0.814	-0.079	3.793	0.016	0.013	0	46.9	37.4	77	143	120	0	34	33	34	
2025	4	14	3	12	55	0.814	-0.075	3.793	0.016	0.013	0	46.9	37.8	77.4	143	120	0	34	32	33	
2025	4	14	3	22	55	0.84	-0.075	3.793	0.01	0.007	0	46.4	37	77.4	142	119	0	34	33	33	
2025	4	14	3	32	55	0.83	-0.131	3.793	0.01	0.007	0	46.4	37.4	77.4	143	119	0	35	32	33	
2025	4	14	3	42	55	0.83	-0.115	3.793	0.013	0.01	0	46.9	37	75.7	143	119	0	34	33	34	
2025	4	14	3	52	55	0.807	-0.075	3.793	0.01	0.007	0	43	37.4	53.3	134	119	0	34	32	34	
2025	4	14	4	2	55	0.83	-0.105	3.793	0.016	0.013	0	46.9	37.8	75.7	143	120	0	34	32	34	
2025	4	14	4	12	55	0.797	-0.082	3.793	0.013	0.01	0	46.4	37	76.5	143	119	0	35	33	33	
2025	4	14	4	22	55	0.81	-0.118	3.793	0.01	0.007	0	46.9	37.8	76.1	143	120	0	34	32	34	
2025	4	14	4	32	55	0.804	-0.085	3.793	0.01	0.007	0	47.3	37.8	76.1	144	121	0	34	33	33	
2025	4	14	4	42	55	0.794	-0.072	3.793	0.013	0.01	0	46.9	37	75.7	143	120	0	34	34	33	
2025	4	14	4	52	55	0.81	-0.089	3.793	0.016	0.013	0	46.9	37.4	75.7	143	120	0	34	33	34	
2025	4	14	5	2	55	0.81	-0.095	3.793	0.013	0.01	0	46.9	37	75.7	143	119	0	34	33	34	
2025	4	14	5	12	55	0.837	-0.079	3.793	0.013	0.01	0	46.9	37	75.7	143	119	0	34	33	33	
2025	4	14	5	22	55	0.817	-0.092	3.793	0.016	0.013	0	46.4	37	74.8	142	119	0	34	33	34	
2025	4	14	5	32	55	0.81	-0.115	3.793	0.013	0.01	0	46	37	76.1	141	118	0	34	32	34	
2025	4	14	5	42	55	0.827	-0.052	3.793	0.01	0.007	0	46	36.5	76.5	141	118	0	34	33	32	
2025	4	14	5	52	55	0.843	-0.069	3.793	0.013	0.01	0	45.6	36.1	75.3	140	117	0	34	33	34	
2025	4	14	6	2	55	0.81	-0.112	3.793	0.01	0.007	0	45.2	35.7	75.3	139	116	0	34	33	33	
2025	4	14	6	12	55	0.843	-0.095	3.793	0.016	0.016	0	45.2	36.1	76.1	139	116	0	34	32	34	
2025	4	14	6	22	55	0.814	-0.062	3.793	0.01	0.007	0	45.6	36.1	75.7	139	116	0	33	32	33	
2025	4	14	6	32	55	0.814	-0.108	3.793	0.013	0.01	0	44.7	35.7	76.1	138	116	0	34	33	33	
2025	4	14	6	42	55	0.804	-0.079	3.793	0.013	0.01	0	44.7	36.1	75.3	138	116	0	34	32	33	
2025	4	14	6	52	55	0.804	-0.079	3.793	0.013	0.01	0	44.3	35.3	76.5	137	115	0	34	33	33	
2025	4	14	7	2	55	0.83	-0.121	3.793	0.013	0.01	0	44.7	35.7	76.1	138	116	0	34	33	33	
2025	4	14	7	12	55	0.817	-0.082	3.793	0.01	0.007	0	44.7	35.3	77	138	115	0	34	33	34	
2025	4	14	7	22	55	0.843	-0.069	3.793	0.01	0.007	0	44.3	34.8	76.5	136	114	0	33	33	33	
2025	4	14	7	32	55	0.801	-0.085	3.796	0.01	0.007	0	43.9	35.3	77	136	114	0	34	32	34	
2025	4	14	7	42	55	0.801	-0.075	3.796	0.01	0.007	0	44.3	35.3	76.5	136	115	0	33	33	33	
2025	4	14	7	52	55	0.817	-0.098	3.793	0.01	0.007	0	43.9	35.3	77.4	136	115	0	34	33	34	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	14	8	2	55	0.83	-0.089	3.796	0.013	0.01	0	43.9	35.3	77.4	136	114	0	34	32	34
2025	4	14	8	12	55	0.827	-0.095	3.796	0.013	0.01	0	44.3	35.3	77	137	115	0	34	33	33
2025	4	14	8	22	55	0.82	-0.079	3.796	0.01	0.007	0	44.7	36.1	73.5	138	116	0	34	32	34
2025	4	14	8	32	55	0.804	-0.089	3.796	0.013	0.01	0	43.9	35.7	74.4	136	115	0	34	32	34
2025	4	14	8	42	55	0.804	-0.098	3.796	0.013	0.01	0	43.9	34.8	78.7	136	114	0	34	33	33
2025	4	14	8	52	55	0.83	-0.141	3.796	0.013	0.01	0	43.4	34.8	79.1	135	113	0	34	32	33
2025	4	14	9	2	55	0.83	-0.066	3.796	0.01	0.007	0	44.3	35.3	78.7	136	114	0	33	32	33
2025	4	14	9	12	55	0.797	-0.108	3.796	0.01	0.007	0	44.3	35.7	78.7	137	115	0	34	32	34
2025	4	14	9	22	55	0.837	-0.089	3.796	0.01	0.007	0	44.3	35.7	78.7	137	115	0	34	32	34
2025	4	14	9	32	55	0.807	-0.052	3.796	0.01	0.007	0	44.7	35.7	77.4	137	115	0	33	32	34
2025	4	14	9	42	55	0.843	-0.095	3.796	0.01	0.007	0	44.3	35.7	77.8	137	116	0	34	33	34
2025	4	14	9	52	55	0.81	-0.059	3.796	0.013	0.01	0	44.3	35.3	65.8	137	115	0	34	33	34
2025	4	14	10	2	55	0.787	-0.072	3.796	0.01	0.007	0	44.3	35.3	78.7	137	115	0	34	33	34
2025	4	14	10	12	55	0.774	-0.069	3.799	0.01	0.007	0	44.7	36.1	78.7	138	116	0	34	32	33
2025	4	14	10	22	55	0.814	-0.105	3.799	0.01	0.007	0	44.3	35.3	79.1	137	114	0	34	32	34
2025	4	14	10	32	55	0.81	-0.105	3.799	0.01	0.007	0	44.3	35.7	79.6	137	115	0	34	32	33
2025	4	14	10	42	55	0.794	-0.102	3.799	0.01	0.007	0	44.7	35.7	79.6	137	115	0	33	32	33
2025	4	14	10	52	55	0.84	-0.102	3.799	0.01	0.007	0	43.9	35.3	78.3	136	114	0	34	32	34
2025	4	14	11	2	55	0.82	-0.092	3.799	0.013	0.01	0	44.3	35.3	78.7	137	115	0	34	33	33
2025	4	14	11	12	55	0.823	-0.108	3.799	0.013	0.01	0	44.3	35.3	76.1	137	115	0	34	33	33
2025	4	14	11	22	55	0.84	-0.085	3.799	0.013	0.01	0	43.9	35.3	78.3	136	114	0	34	32	33
2025	4	14	11	32	55	0.801	-0.069	3.799	0.013	0.01	0	44.3	35.7	78.3	137	115	0	34	32	33
2025	4	14	11	42	55	0.778	-0.089	3.799	0.01	0.007	0	43.9	34.8	78.7	136	114	0	34	33	33
2025	4	14	11	52	55	0.774	-0.092	3.799	0.013	0.01	0	44.3	35.3	77.8	136	114	0	33	32	34
2025	4	14	12	2	55	0.807	-0.075	3.799	0.01	0.007	0	44.3	35.7	77.4	136	115	0	33	32	33
2025	4	14	12	12	55	0.817	-0.089	3.799	0.013	0.01	0	44.3	35.3	75.7	137	115	0	34	33	33
2025	4	14	12	22	55	0.797	-0.075	3.796	0.01	0.007	0	44.3	35.7	52	137	115	0	34	32	33
2025	4	14	12	32	55	0.801	-0.062	3.802	0.01	0.007	0	44.7	35.7	77	137	115	0	33	32	34
2025	4	14	12	42	55	0.758	-0.079	3.799	0.016	0.013	0	44.3	35.7	76.5	136	115	0	33	32	34
2025	4	14	12	52	55	0.758	-0.069	3.802	0.01	0.007	0	44.3	35.7	71.8	137	115	0	34	32	33
2025	4	14	13	2	55	0.814	-0.095	3.799	0.01	0.007	0	45.2	36.1	49.5	138	116	0	33	32	33
2025	4	14	13	12	55	0.781	-0.075	3.802	0.016	0.013	0	44.7	35.7	73.1	137	115	0	33	32	33
2025	4	14	13	22	55	0.794	-0.082	3.799	0.016	0.013	0	44.3	35.7	50.3	137	115	0	34	32	33
2025	4	14	13	32	55	0.843	-0.092	3.799	0.013	0.01	0	44.3	35.7	47.7	137	115	0	34	32	33
2025	4	14	13	42	55	0.827	-0.105	3.802	0.013	0.01	0	44.3	35.7	52.5	137	115	0	34	32	32
2025	4	14	13	52	55	0.794	-0.059	3.799	0.01	0.007	0	45.2	36.1	46.4	138	116	0	33	32	34
2025	4	14	14	2	55	0.804	-0.098	3.802	0.013	0.01	0	44.7	36.1	57.2	138	116	0	34	32	34
2025	4	14	14	12	55	0.823	-0.102	3.802	0.013	0.01	0	44.7	35.3	49.5	138	115	0	34	33	34
2025	4	14	14	22	55	0.791	-0.052	3.799	0.016	0.013	0	44.7	35.3	46.9	138	115	0	34	33	32
2025	4	14	14	32	55	0.814	-0.052	3.806	0.016	0.013	0	44.3	35.7	71.4	137	115	0	34	32	33
2025	4	14	14	42	55	0.82	-0.072	3.806	0.01	0.007	0	44.7	36.1	68.4	138	116	0	34	32	33
2025	4	14	14	52	55	0.801	-0.056	3.802	0.01	0.007	0	44.7	35.7	46	138	115	0	34	32	32
2025	4	14	15	2	55	0.823	-0.075	3.802	0.01	0.007	0	44.3	35.7	52.9	137	115	0	34	32	33
2025	4	14	15	12	55	0.843	-0.075	3.802	0.013	0.01	0	44.7	36.5	59.3	138	116	0	34	31	33
2025	4	14	15	22	55	0.774	-0.079	3.802	0.01	0.007	0	44.7	35.7	46	138	116	0	34	33	33
2025	4	14	15	32	55	0.817	-0.089	3.802	0.013	0.01	0	44.7	36.1	48.2	138	116	0	34	32	33
2025	4	14	15	42	55	0.804	-0.069	3.802	0.016	0.013	0	45.2	36.1	43.4	139	116	0	34	32	34
2025	4	14	15	52	55	0.804	-0.118	3.802	0.013	0.01	0	44.3	35.3	51.2	137	115	0	34	33	33

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	4	14	16	2	55	0.81	-0.075	3.802	0.01	0.007	0	45.2	35.3	46	138	115	0	33	33	33	
2025	4	14	16	12	55	0.817	-0.089	3.802	0.01	0.007	0	44.3	35.7	44.3	137	115	0	34	32	33	
2025	4	14	16	22	55	0.833	-0.075	3.802	0.016	0.013	0	44.3	35.3	44.3	137	114	0	34	32	33	
2025	4	14	16	32	55	0.784	-0.023	3.802	0.013	0.01	0	44.3	35.3	44.7	137	114	0	34	32	33	
2025	4	14	16	42	55	0.807	-0.062	3.802	0.013	0.01	0	44.7	35.7	51.2	137	115	0	33	32	33	
2025	4	14	16	52	55	0.807	-0.089	3.806	0.013	0.01	0	44.7	35.3	59.8	137	114	0	33	32	33	
2025	4	14	17	2	55	0.82	-0.092	3.806	0.016	0.013	0	44.3	34.8	56.8	137	114	0	34	33	33	
2025	4	14	17	12	55	0.797	-0.118	3.806	0.013	0.01	0	44.3	35.3	59.3	137	114	0	34	32	33	
2025	4	14	17	22	55	0.823	-0.062	3.806	0.013	0.01	0	44.3	35.3	69.7	137	114	0	34	32	33	
2025	4	14	17	32	55	0.81	-0.105	3.806	0.013	0.01	0	44.3	35.3	77	137	114	0	34	32	34	
2025	4	14	17	42	55	0.804	-0.108	3.806	0.013	0.01	0	44.7	35.3	78.3	137	114	0	33	32	32	
2025	4	14	17	52	55	0.823	-0.085	3.806	0.016	0.013	0	44.7	35.7	74	138	115	0	34	32	33	
2025	4	14	18	2	55	0.846	-0.095	3.806	0.013	0.01	0	44.7	35.7	77	138	115	0	34	32	33	
2025	4	14	18	12	55	0.853	-0.089	3.806	0.016	0.013	0	45.2	35.7	76.5	138	115	0	33	32	34	
2025	4	14	18	22	55	0.807	-0.112	3.806	0.013	0.01	0	45.2	36.1	73.5	139	116	0	34	32	33	
2025	4	14	18	32	55	0.84	-0.121	3.806	0.016	0.016	0	45.2	35.7	77	139	116	0	34	33	33	
2025	4	14	18	42	55	0.82	-0.098	3.806	0.013	0.01	0	45.2	36.1	75.3	139	116	0	34	32	33	
2025	4	14	18	52	55	0.866	-0.105	3.806	0.013	0.01	0	46	37	76.5	141	118	0	34	32	33	
2025	4	14	19	2	55	0.784	-0.102	3.806	0.016	0.013	0	46.9	37.4	76.5	142	119	0	33	32	33	
2025	4	14	19	12	55	0.823	-0.105	3.806	0.01	0.007	0	46.4	37.4	75.3	142	119	0	34	32	34	
2025	4	14	19	22	55	0.84	-0.112	3.806	0.016	0.013	0	46.9	37.4	76.1	142	119	0	33	32	33	
2025	4	14	19	32	55	0.843	-0.118	3.806	0.013	0.01	0	46.4	37	76.1	142	119	0	34	33	33	
2025	4	14	19	42	55	0.823	-0.105	3.806	0.013	0.01	0	46.4	37.4	75.3	142	119	0	34	32	33	
2025	4	14	19	52	55	0.843	-0.085	3.806	0.013	0.01	0	46	37.4	75.7	141	119	0	34	32	33	
2025	4	14	20	2	55	0.833	-0.105	3.806	0.01	0.007	0	46.4	37.4	76.1	142	119	0	34	32	32	
2025	4	14	20	12	55	0.837	-0.075	3.806	0.01	0.007	0	46.4	37	76.1	142	119	0	34	33	33	
2025	4	14	20	22	55	0.86	-0.105	3.806	0.016	0.013	0	46.9	37	75.7	142	119	0	33	33	33	
2025	4	14	20	32	55	0.81	-0.085	3.806	0.016	0.013	0	46	36.5	75.3	141	118	0	34	33	34	
2025	4	14	20	42	55	0.801	-0.121	3.806	0.016	0.016	0	46	37	75.3	141	118	0	34	32	33	
2025	4	14	20	52	55	0.85	-0.118	3.806	0.01	0.007	0	46	37	74.8	141	118	0	34	32	33	
2025	4	14	21	2	55	0.82	-0.108	3.806	0.01	0.007	0	46	36.5	71	141	118	0	34	33	32	
2025	4	14	21	12	55	0.797	-0.089	3.806	0.013	0.01	0	46.9	36.5	59.3	142	118	0	33	33	34	
2025	4	14	21	22	55	0.856	-0.108	3.806	0.016	0.016	0	46.4	37	74	142	118	0	34	32	33	
2025	4	14	21	32	55	0.837	-0.059	3.806	0.01	0.007	0	46.4	36.5	75.3	142	118	0	34	33	32	
2025	4	14	21	42	55	0.82	-0.108	3.806	0.01	0.007	0	46	36.1	74.4	141	117	0	34	33	34	
2025	4	14	21	52	55	0.85	-0.085	3.806	0.013	0.01	0	46.9	37	74	142	118	0	33	32	34	
2025	4	14	22	2	55	0.833	-0.072	3.806	0.01	0.007	0	46.4	36.5	74.4	142	118	0	34	33	33	
2025	4	14	22	12	55	0.846	-0.092	3.806	0.013	0.01	0	46	37	74.4	141	118	0	34	32	33	
2025	4	14	22	22	55	0.83	-0.089	3.806	0.016	0.013	0	46	37	74	141	118	0	34	32	33	
2025	4	14	22	32	55	0.827	-0.112	3.806	0.01	0.007	0	46.4	36.5	74	142	118	0	34	33	34	
2025	4	14	22	42	55	0.83	-0.056	3.806	0.01	0.007	0	46	36.1	74.4	141	117	0	34	33	33	
2025	4	14	22	52	55	0.843	-0.095	3.809	0.01	0.007	0	46.4	36.5	74	141	117	0	33	32	33	
2025	4	14	23	2	55	0.81	-0.079	3.809	0.013	0.01	0	46.4	37	74.4	142	118	0	34	32	33	
2025	4	14	23	12	55	0.846	-0.092	3.809	0.013	0.01	0	46	37	74.8	141	118	0	34	32	33	
2025	4	14	23	22	55	0.833	-0.075	3.809	0.013	0.01	0	46.4	36.1	74.4	141	117	0	33	33	33	
2025	4	14	23	32	55	0.82	-0.075	3.812	0.013	0.01	0	46.4	37	73.1	142	118	0	34	32	34	
2025	4	14	23	42	55	0.823	-0.098	3.812	0.01	0.007	0	46	36.5	74.4	141	117	0	34	32	33	
2025	4	14	23	52	55	0.86	-0.112	3.812	0.013	0.01	0	46	36.1	74	141	117	0	34	33	34	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	15	0	2	55	0.833	-0.102	3.812	0.01	0.007	0	46	36.5	73.1	141	117	0	34	32	34
2025	4	15	0	12	55	0.801	-0.105	3.812	0.016	0.013	0	46	37	73.5	141	118	0	34	32	33
2025	4	15	0	22	55	0.856	-0.082	3.816	0.013	0.01	0	45.6	36.5	74	140	117	0	34	32	33
2025	4	15	0	32	55	0.846	-0.079	3.816	0.01	0.007	0	45.6	36.1	74.4	141	117	0	35	33	33
2025	4	15	0	42	55	0.83	-0.085	3.816	0.01	0.007	0	46	37	74.4	141	118	0	34	32	33
2025	4	15	0	52	55	0.84	-0.082	3.816	0.013	0.01	0	46	36.1	73.5	141	117	0	34	33	34
2025	4	15	1	2	55	0.856	-0.089	3.816	0.016	0.013	0	46	36.1	74	141	117	0	34	33	34
2025	4	15	1	12	55	0.873	-0.108	3.819	0.01	0.007	0	46	36.1	74.8	141	117	0	34	33	33
2025	4	15	1	22	55	0.846	-0.115	3.819	0.013	0.01	0	46	36.1	74.8	141	117	0	34	33	33
2025	4	15	1	32	55	0.801	-0.085	3.819	0.01	0.007	0	46	36.5	74	141	118	0	34	33	34
2025	4	15	1	42	55	0.837	-0.056	3.816	0.013	0.01	0	46	36.1	73.5	141	117	0	34	33	34
2025	4	15	1	52	55	0.787	-0.085	3.816	0.013	0.01	0	46.4	37	73.5	142	118	0	34	32	34
2025	4	15	2	2	55	0.817	-0.115	3.819	0.01	0.007	0	46	36.1	74	141	117	0	34	33	33
2025	4	15	2	12	55	0.81	-0.069	3.819	0.013	0.01	0	46	36.1	74	141	117	0	34	33	33
2025	4	15	2	22	55	0.853	-0.089	3.816	0.013	0.01	0	45.6	36.1	74.4	140	117	0	34	33	33
2025	4	15	2	32	55	0.83	-0.085	3.819	0.01	0.007	0	45.6	35.7	74.4	140	116	0	34	33	33
2025	4	15	2	42	55	0.866	-0.118	3.819	0.013	0.01	0	46	36.1	73.5	141	117	0	34	33	33
2025	4	15	2	52	55	0.827	-0.069	3.819	0.013	0.01	0	46	36.5	73.1	141	117	0	34	32	34
2025	4	15	3	2	55	0.814	-0.089	3.819	0.016	0.016	0	46	36.1	73.1	141	117	0	34	33	33
2025	4	15	3	12	55	0.804	-0.079	3.819	0.01	0.007	0	46.4	36.5	72.7	142	118	0	34	33	34
2025	4	15	3	22	55	0.837	-0.085	3.819	0.013	0.01	0	46	36.5	74	141	117	0	34	32	33
2025	4	15	3	32	55	0.817	-0.066	3.816	0.016	0.016	0	46	36.5	72.7	141	118	0	34	33	33
2025	4	15	3	42	55	0.843	-0.098	3.819	0.013	0.01	0	46	36.5	73.5	141	117	0	34	32	33
2025	4	15	3	52	55	0.827	-0.098	3.819	0.016	0.013	0	46	36.1	72.2	141	117	0	34	33	34
2025	4	15	4	2	55	0.804	-0.095	3.816	0.01	0.007	0	45.6	36.1	71.8	140	117	0	34	33	34
2025	4	15	4	12	55	0.83	-0.046	3.819	0.01	0.007	0	46	36.1	73.5	141	117	0	34	33	33
2025	4	15	4	22	55	0.84	-0.085	3.819	0.01	0.007	0	46.9	36.1	73.5	143	117	0	34	33	34
2025	4	15	4	32	55	0.853	-0.102	3.819	0.016	0.013	0	47.3	36.1	73.1	143	117	0	33	33	33
2025	4	15	4	42	55	0.853	-0.095	3.819	0.013	0.01	0	46.9	36.1	74.4	143	117	0	34	33	34
2025	4	15	4	52	55	0.83	-0.121	3.819	0.01	0.007	0	46.4	36.1	74.4	142	117	0	34	33	33
2025	4	15	5	2	55	0.846	-0.072	3.819	0.013	0.01	0	46.4	36.1	73.5	142	117	0	34	33	33
2025	4	15	5	12	55	0.814	-0.069	3.819	0.013	0.01	0	46.9	36.5	73.5	143	117	0	34	32	33
2025	4	15	5	22	55	0.823	-0.049	3.819	0.016	0.013	0	46.4	36.1	74.4	142	117	0	34	33	33
2025	4	15	5	32	55	0.833	-0.115	3.819	0.013	0.01	0	46	35.3	74.8	141	115	0	34	33	34
2025	4	15	5	42	55	0.804	-0.046	3.819	0.01	0.007	0	46	35.7	75.7	141	116	0	34	33	33
2025	4	15	5	52	55	0.814	-0.075	3.819	0.013	0.01	0	45.6	34.8	76.1	140	115	0	34	34	33
2025	4	15	6	2	55	0.814	-0.102	3.819	0.016	0.013	0	46	34.8	76.1	140	114	0	33	33	33
2025	4	15	6	12	55	0.843	-0.105	3.819	0.01	0.007	0	44.3	34.8	74.4	138	113	0	35	32	34
2025	4	15	6	22	55	0.837	-0.062	3.819	0.013	0.01	0	45.2	34.4	75.3	139	113	0	34	33	34
2025	4	15	6	32	55	0.807	-0.082	3.819	0.013	0.01	0	45.2	34.4	76.1	139	113	0	34	33	34
2025	4	15	6	42	55	0.801	-0.072	3.819	0.01	0.007	0	45.2	34.4	75.7	139	113	0	34	33	33
2025	4	15	6	52	55	0.807	-0.066	3.819	0.013	0.01	0	44.7	34	73.1	138	112	0	34	33	34
2025	4	15	7	2	55	0.804	-0.102	3.819	0.01	0.007	0	44.3	34.4	74.8	138	112	0	35	32	33
2025	4	15	7	12	55	0.814	-0.079	3.819	0.01	0.007	0	45.6	34.8	74.8	139	113	0	33	32	33
2025	4	15	7	22	55	0.833	-0.102	3.819	0.013	0.01	0	45.2	34.8	73.5	139	114	0	34	33	34
2025	4	15	7	32	55	0.817	-0.075	3.819	0.013	0.01	0	44.7	34.8	73.5	138	113	0	34	32	34
2025	4	15	7	42	55	0.81	-0.085	3.819	0.01	0.007	0	45.6	35.3	74	140	115	0	34	33	34
2025	4	15	7	52	55	0.814	-0.089	3.816	0.01	0.007	0	45.6	35.7	74	140	115	0	34	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	15	8	2	55	0.794	-0.085	3.816	0.013	0.01	0	45.6	35.3	74	140	115	0	34	33	33
2025	4	15	8	12	55	0.807	-0.075	3.816	0.016	0.013	0	45.6	35.3	73.1	140	115	0	34	33	35
2025	4	15	8	22	55	0.827	-0.089	3.812	0.013	0.01	0	45.6	35.3	74	140	115	0	34	33	34
2025	4	15	8	32	55	0.823	-0.108	3.812	0.013	0.01	0	45.6	35.7	74.4	140	115	0	34	32	34
2025	4	15	8	42	55	0.817	-0.079	3.812	0.01	0.007	0	45.2	35.3	74.4	139	115	0	34	33	34
2025	4	15	8	52	55	0.827	-0.089	3.812	0.013	0.01	0	45.6	35.3	74.8	140	115	0	34	33	33
2025	4	15	9	2	55	0.837	-0.069	3.809	0.01	0.007	0	45.6	35.3	74.8	140	115	0	34	33	34
2025	4	15	9	12	55	0.794	-0.089	3.809	0.01	0.007	0	45.6	34.8	75.3	139	114	0	33	33	33
2025	4	15	9	22	55	0.82	-0.066	3.809	0.013	0.01	0	45.6	35.3	76.1	140	115	0	34	33	33
2025	4	15	9	32	55	0.807	-0.062	3.809	0.016	0.013	0	45.2	34.8	75.7	139	114	0	34	33	34
2025	4	15	9	42	55	0.86	-0.079	3.809	0.01	0.007	0	45.6	34.8	74.8	139	114	0	33	33	34
2025	4	15	9	52	55	0.801	-0.118	3.809	0.01	0.007	0	45.6	35.3	73.1	140	115	0	34	33	34
2025	4	15	10	2	55	0.85	-0.095	3.806	0.013	0.01	0	45.2	40	64.9	139	125	0	34	32	33
2025	4	15	10	12	55	0.784	-0.075	3.806	0.013	0.01	0	45.2	40	56.3	139	125	0	34	32	33
2025	4	15	10	22	55	0.85	-0.112	3.806	0.013	0.01	0	44.7	39.1	56.3	138	124	0	34	33	33
2025	4	15	10	32	55	0.817	-0.095	3.806	0.016	0.013	0	45.2	39.6	65.4	139	124	0	34	32	33
2025	4	15	10	42	55	0.83	-0.108	3.806	0.01	0.007	0	45.2	39.6	54.6	139	124	0	34	32	33
2025	4	15	10	52	55	0.823	-0.095	3.806	0.013	0.01	0	45.2	39.6	66.7	139	125	0	34	33	33
2025	4	15	11	2	55	0.823	-0.102	3.806	0.013	0.01	0	45.2	39.6	52.5	139	125	0	34	33	33
2025	4	15	11	12	55	0.787	-0.059	3.809	0.013	0.01	0	45.6	40	50.7	140	125	0	34	32	33
2025	4	15	11	22	55	0.827	-0.098	3.809	0.01	0.007	0	45.6	40	49.5	140	125	0	34	32	34
2025	4	15	11	32	55	0.801	-0.079	3.809	0.01	0.007	0	45.6	40.4	48.6	140	126	0	34	32	33
2025	4	15	11	42	55	0.843	-0.118	3.806	0.01	0.007	0	45.6	39.6	52.9	140	125	0	34	33	33
2025	4	15	11	52	55	0.81	-0.118	3.806	0.01	0.007	0	45.6	40	51.6	140	125	0	34	32	33
2025	4	15	12	2	55	0.797	-0.075	3.809	0.01	0.007	0	45.2	39.6	53.3	139	125	0	34	33	34
2025	4	15	12	12	55	0.807	-0.075	3.806	0.013	0.01	0	45.6	40.4	53.8	140	126	0	34	32	34
2025	4	15	12	22	55	0.83	-0.066	3.809	0.013	0.01	0	45.6	40	49	139	125	0	33	32	34
2025	4	15	12	32	55	0.794	-0.098	3.809	0.01	0.007	0	45.6	39.6	49.9	139	125	0	33	33	33
2025	4	15	12	42	55	0.83	-0.115	3.809	0.013	0.01	0	45.6	39.6	49.5	140	125	0	34	33	33
2025	4	15	12	52	55	0.817	-0.082	3.809	0.01	0.007	0	46	40.4	51.2	140	126	0	33	32	33
2025	4	15	13	2	55	0.804	-0.085	3.806	0.01	0.007	0	45.6	40	48.2	140	126	0	34	33	34
2025	4	15	13	12	55	0.866	-0.079	3.809	0.013	0.01	0	46	40.4	48.6	141	127	0	34	33	33
2025	4	15	13	22	55	0.807	-0.089	3.806	0.016	0.013	0	46.4	40.9	49	141	127	0	33	32	33
2025	4	15	13	32	55	0.791	-0.075	3.812	0.013	0.01	0	46.4	40.9	49	141	127	0	33	32	33
2025	4	15	13	42	55	0.787	-0.056	3.809	0.013	0.01	0	46.4	40.9	47.7	141	127	0	33	32	34
2025	4	15	13	52	55	0.781	-0.069	3.809	0.01	0.007	0	45.6	40.4	50.3	140	126	0	34	32	33
2025	4	15	14	2	55	0.791	-0.102	3.809	0.013	0.01	0	45.6	40	49.9	140	126	0	34	33	33
2025	4	15	14	12	55	0.81	-0.108	3.809	0.01	0.007	0	46	40.9	49.5	141	127	0	34	32	33
2025	4	15	14	22	55	0.81	-0.092	3.809	0.01	0.007	0	46	40.4	48.6	140	126	0	33	32	33
2025	4	15	14	32	55	0.833	-0.049	3.809	0.01	0.007	0	45.6	40.4	49.9	140	126	0	34	32	33
2025	4	15	14	42	55	0.846	-0.079	3.809	0.01	0.007	0	46	40.4	56.3	140	127	0	33	33	33
2025	4	15	14	52	55	0.833	-0.079	3.809	0.016	0.013	0	46.4	40.4	46	141	127	0	33	33	33
2025	4	15	15	2	55	0.846	-0.095	3.809	0.013	0.01	0	45.6	40.9	49.5	140	127	0	34	32	33
2025	4	15	15	12	55	0.817	-0.089	3.809	0.013	0.01	0	46.4	40.9	49	141	127	0	33	32	33
2025	4	15	15	22	55	0.804	-0.105	3.809	0.01	0.007	0	46.4	40.9	49.9	142	127	0	34	32	33
2025	4	15	15	32	55	0.804	-0.066	3.809	0.01	0.007	0	46.9	41.3	51.2	142	128	0	33	32	33
2025	4	15	15	42	55	0.823	-0.095	3.809	0.01	0.007	0	46	40.9	58.9	141	127	0	34	32	34
2025	4	15	15	52	55	0.82	-0.095	3.806	0.013	0.01	0	46	40.4	47.3	141	127	0	34	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	15	16	2	55	0.794	-0.072	3.809	0.01	0.007	0	46	40.9	52	141	127	0	34	32	33
2025	4	15	16	12	55	0.837	-0.105	3.806	0.01	0.007	0	46	40.4	53.8	140	126	0	33	32	33
2025	4	15	16	22	55	0.827	-0.118	3.806	0.01	0.007	0	46	40.4	53.8	141	126	0	34	32	33
2025	4	15	16	32	55	0.81	-0.105	3.809	0.013	0.01	0	46.4	40.9	52.9	141	127	0	33	32	33
2025	4	15	16	42	55	0.85	-0.118	3.806	0.01	0.007	0	45.6	40.4	67.1	140	126	0	34	32	33
2025	4	15	16	52	55	0.81	-0.072	3.806	0.013	0.01	0	46	40	55	141	126	0	34	33	32
2025	4	15	17	2	55	0.817	-0.052	3.806	0.013	0.01	0	46	40.4	57.2	141	126	0	34	32	33
2025	4	15	17	12	55	0.856	-0.085	3.806	0.01	0.007	0	45.6	40	69.7	140	126	0	34	33	33
2025	4	15	17	22	55	0.817	-0.075	3.806	0.01	0.007	0	46	40.9	58.9	141	127	0	34	32	34
2025	4	15	17	32	55	0.86	-0.056	3.806	0.016	0.013	0	46.4	40	54.2	141	126	0	33	33	33
2025	4	15	17	42	55	0.817	-0.092	3.806	0.016	0.013	0	46	40.9	62.4	141	127	0	34	32	33
2025	4	15	17	52	55	0.804	-0.082	3.806	0.016	0.013	0	46.4	40.9	72.7	142	127	0	34	32	33
2025	4	15	18	2	55	0.817	-0.072	3.806	0.01	0.007	0	46.9	41.3	73.1	142	128	0	33	32	34
2025	4	15	18	12	55	0.86	-0.118	3.806	0.013	0.01	0	46.9	40.9	73.1	142	127	0	33	32	33
2025	4	15	18	22	55	0.827	-0.131	3.806	0.013	0.01	0	46.9	41.3	74	142	128	0	33	32	33
2025	4	15	18	32	55	0.833	-0.118	3.806	0.01	0.007	0	46.4	41.3	73.5	142	128	0	34	32	34
2025	4	15	18	42	55	0.843	-0.131	3.806	0.013	0.01	0	46.9	40.9	68.4	143	128	0	34	33	32
2025	4	15	18	52	55	0.807	-0.085	3.806	0.016	0.013	0	47.7	41.7	51.2	144	130	0	33	33	33
2025	4	15	19	2	55	0.837	-0.118	3.806	0.013	0.01	0	47.7	42.1	72.2	144	130	0	33	32	34
2025	4	15	19	12	55	0.827	-0.112	3.802	0.01	0.007	0	47.7	42.6	72.2	145	131	0	34	32	33
2025	4	15	19	22	55	0.81	-0.118	3.802	0.01	0.007	0	47.7	42.6	73.1	145	131	0	34	32	33
2025	4	15	19	32	55	0.81	-0.085	3.802	0.01	0.007	0	47.7	42.1	72.2	145	131	0	34	33	33
2025	4	15	19	42	55	0.823	-0.089	3.802	0.013	0.01	0	47.7	42.6	72.2	145	131	0	34	32	34
2025	4	15	19	52	55	0.856	-0.082	3.802	0.013	0.01	0	47.7	42.1	72.7	145	130	0	34	32	33
2025	4	15	20	2	55	0.81	-0.062	3.802	0.013	0.01	0	47.7	42.6	71.8	145	131	0	34	32	33
2025	4	15	20	12	55	0.837	-0.049	3.802	0.013	0.01	0	48.2	42.6	71.8	145	131	0	33	32	34
2025	4	15	20	22	55	0.814	-0.092	3.802	0.013	0.01	0	47.3	42.1	72.7	144	130	0	34	32	33
2025	4	15	20	32	55	0.787	-0.092	3.802	0.016	0.013	0	47.3	41.7	68.4	144	130	0	34	33	34
2025	4	15	20	42	55	0.85	-0.164	3.799	0.01	0.007	0	47.3	41.7	71.8	144	130	0	34	33	34
2025	4	15	20	52	55	0.801	-0.079	3.802	0.01	0.007	0	47.3	41.7	70.5	144	130	0	34	33	33
2025	4	15	21	2	55	0.833	-0.118	3.802	0.01	0.007	0	47.3	42.1	72.7	144	130	0	34	32	34
2025	4	15	21	12	55	0.817	-0.069	3.799	0.016	0.013	0	47.3	41.7	71.8	144	130	0	34	33	33
2025	4	15	21	22	55	0.827	-0.105	3.799	0.016	0.013	0	47.3	41.7	72.2	144	129	0	34	32	34
2025	4	15	21	32	55	0.82	-0.135	3.799	0.016	0.013	0	47.7	41.7	72.7	144	130	0	33	33	33
2025	4	15	21	42	55	0.84	-0.102	3.799	0.013	0.01	0	47.3	42.1	72.2	144	130	0	34	32	33
2025	4	15	21	52	55	0.804	-0.095	3.799	0.013	0.01	0	47.7	42.1	72.2	145	130	0	34	32	34
2025	4	15	22	2	55	0.837	-0.085	3.799	0.013	0.01	0	47.3	41.3	72.2	144	129	0	34	33	34
2025	4	15	22	12	55	0.83	-0.082	3.799	0.013	0.01	0	47.3	41.3	71.8	144	129	0	34	33	33
2025	4	15	22	22	55	0.827	-0.089	3.799	0.01	0.007	0	46.9	41.7	72.2	144	130	0	35	33	34
2025	4	15	22	32	55	0.846	-0.118	3.799	0.016	0.013	0	47.3	42.1	72.2	144	130	0	34	32	33
2025	4	15	22	42	55	0.797	-0.075	3.799	0.01	0.007	0	47.7	41.7	71	145	130	0	34	33	34
2025	4	15	22	52	55	0.853	-0.089	3.799	0.01	0.007	0	47.3	42.1	72.2	144	130	0	34	32	33
2025	4	15	23	2	55	0.846	-0.085	3.799	0.013	0.01	0	48.2	42.1	71.8	145	130	0	33	32	33
2025	4	15	23	12	55	0.801	-0.108	3.799	0.01	0.007	0	47.3	41.7	71.4	144	130	0	34	33	34
2025	4	15	23	22	55	0.833	-0.125	3.799	0.01	0.007	0	47.3	41.7	71.8	144	129	0	34	32	33
2025	4	15	23	32	55	0.853	-0.089	3.799	0.01	0.007	0	47.3	41.7	71.4	144	130	0	34	33	34
2025	4	15	23	42	55	0.856	-0.098	3.799	0.013	0.01	0	47.3	41.7	71.8	144	129	0	34	32	34
2025	4	15	23	52	55	0.837	-0.112	3.799	0.013	0.01	0	46.9	41.7	71.4	144	130	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	16	0	2	55	0.837	-0.095	3.799	0.016	0.013	0	47.3	41.7	71.4	144	130	0	34	33	33
2025	4	16	0	12	55	0.833	-0.098	3.799	0.013	0.01	0	47.3	41.3	72.2	144	129	0	34	33	33
2025	4	16	0	22	55	0.82	-0.105	3.796	0.013	0.01	0	47.3	40.9	71.8	144	129	0	34	34	34
2025	4	16	0	32	55	0.801	-0.105	3.799	0.013	0.01	0	47.3	41.3	71	144	129	0	34	33	33
2025	4	16	0	42	55	0.83	-0.105	3.796	0.013	0.01	0	47.3	41.7	71.8	144	130	0	34	33	33
2025	4	16	0	52	55	0.771	-0.059	3.796	0.01	0.007	0	46.9	41.7	71.4	144	130	0	35	33	34
2025	4	16	1	2	55	0.84	-0.092	3.796	0.013	0.01	0	46.9	41.7	72.2	144	130	0	35	33	33
2025	4	16	1	12	55	0.82	-0.085	3.796	0.01	0.007	0	46.9	41.3	72.2	143	129	0	34	33	33
2025	4	16	1	22	55	0.833	-0.098	3.799	0.013	0.01	0	46.9	41.3	72.2	143	129	0	34	33	33
2025	4	16	1	32	55	0.86	-0.108	3.799	0.016	0.013	0	47.3	41.3	71.8	144	129	0	34	33	34
2025	4	16	1	42	55	0.873	-0.092	3.796	0.01	0.007	0	46.9	41.3	70.1	143	129	0	34	33	34
2025	4	16	1	52	55	0.804	-0.079	3.796	0.016	0.013	0	46.9	41.7	71.4	143	130	0	34	33	34
2025	4	16	2	2	55	0.873	-0.085	3.796	0.013	0.01	0	47.3	40.9	72.7	143	128	0	33	33	33
2025	4	16	2	12	55	0.84	-0.102	3.796	0.013	0.01	0	46.9	41.7	72.2	143	130	0	34	33	33
2025	4	16	2	22	55	0.84	-0.082	3.796	0.016	0.013	0	46.4	41.7	72.2	142	129	0	34	32	33
2025	4	16	2	32	55	0.768	-0.105	3.796	0.016	0.013	0	46	41.7	72.2	142	129	0	35	32	33
2025	4	16	2	42	55	0.843	-0.069	3.796	0.01	0.007	0	46.4	41.7	72.7	142	129	0	34	32	33
2025	4	16	2	52	55	0.814	-0.075	3.796	0.01	0.007	0	47.3	41.7	71.4	143	130	0	33	33	33
2025	4	16	3	2	55	0.82	-0.115	3.796	0.013	0.01	0	46.4	41.7	72.2	142	130	0	34	33	34
2025	4	16	3	12	55	0.807	-0.105	3.796	0.01	0.007	0	46.4	41.3	72.7	142	129	0	34	33	33
2025	4	16	3	22	55	0.83	-0.072	3.796	0.01	0.007	0	46.9	42.1	71.8	143	130	0	34	32	33
2025	4	16	3	32	55	0.801	-0.072	3.796	0.013	0.01	0	46.9	41.7	71.8	143	130	0	34	33	33
2025	4	16	3	42	55	0.853	-0.062	3.796	0.01	0.007	0	46.9	41.3	71.8	143	129	0	34	33	34
2025	4	16	3	52	55	0.833	-0.075	3.796	0.013	0.01	0	46.9	42.1	72.2	143	130	0	34	32	33
2025	4	16	4	2	55	0.827	-0.105	3.796	0.01	0.007	0	46.9	41.3	72.2	143	129	0	34	33	34
2025	4	16	4	12	55	0.817	-0.115	3.796	0.013	0.01	0	47.3	41.7	72.2	144	130	0	34	33	33
2025	4	16	4	22	55	0.823	-0.066	3.796	0.01	0.007	0	46.9	41.3	72.2	143	129	0	34	33	33
2025	4	16	4	32	55	0.817	-0.072	3.796	0.013	0.01	0	47.3	41.7	72.7	144	130	0	34	33	33
2025	4	16	4	42	55	0.814	-0.079	3.796	0.013	0.01	0	46.9	41.3	72.2	143	129	0	34	33	34
2025	4	16	4	52	55	0.82	-0.079	3.796	0.013	0.01	0	47.3	41.7	72.2	144	130	0	34	33	34
2025	4	16	5	2	55	0.869	-0.089	3.796	0.01	0.007	0	46.9	41.7	72.2	143	130	0	34	33	33
2025	4	16	5	12	55	0.814	-0.072	3.796	0.013	0.01	0	46.4	41.7	72.7	143	129	0	35	32	33
2025	4	16	5	22	55	0.856	-0.085	3.796	0.01	0.007	0	46.9	41.3	72.7	143	129	0	34	33	34
2025	4	16	5	32	55	0.804	-0.089	3.796	0.01	0.007	0	46.9	40.9	72.7	143	129	0	34	34	34
2025	4	16	5	42	55	0.856	-0.066	3.796	0.01	0.007	0	46.4	41.3	72.7	142	128	0	34	32	34
2025	4	16	5	52	55	0.883	-0.131	3.796	0.01	0.007	0	45.6	40	73.5	140	126	0	34	33	33
2025	4	16	6	2	55	0.84	-0.082	3.796	0.01	0.007	0	45.2	39.1	73.1	139	125	0	34	34	33
2025	4	16	6	12	55	0.823	-0.092	3.796	0.013	0.01	0	45.2	39.6	73.1	139	125	0	34	33	34
2025	4	16	6	22	55	0.843	-0.072	3.796	0.013	0.01	0	44.7	39.1	74	138	124	0	34	33	33
2025	4	16	6	32	55	0.817	-0.075	3.796	0.01	0.007	0	45.2	39.1	74	139	124	0	34	33	33
2025	4	16	6	42	55	0.814	-0.098	3.796	0.013	0.01	0	44.3	39.1	74	137	123	0	34	32	34
2025	4	16	6	52	55	0.823	-0.066	3.796	0.013	0.01	0	43.9	38.7	74.8	136	123	0	34	33	32
2025	4	16	7	2	55	0.82	-0.095	3.799	0.013	0.01	0	43.9	38.3	74.8	136	121	0	34	32	33
2025	4	16	7	12	55	0.843	-0.102	3.796	0.013	0.01	0	44.3	38.3	74	136	122	0	33	33	34
2025	4	16	7	22	55	0.817	-0.095	3.796	0.016	0.013	0	43.9	39.6	74	137	124	0	35	32	34
2025	4	16	7	32	55	0.827	-0.075	3.799	0.01	0.007	0	44.3	39.1	73.1	137	123	0	34	32	33
2025	4	16	7	42	55	0.797	-0.072	3.799	0.013	0.01	0	44.3	39.6	70.1	137	124	0	34	32	34
2025	4	16	7	52	55	0.823	-0.108	3.799	0.013	0.01	0	44.3	39.1	74	137	124	0	34	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	16	8	2	55	0.823	-0.092	3.799	0.016	0.013	0	45.2	40	74	139	126	0	34	33	33
2025	4	16	8	12	55	0.843	-0.046	3.799	0.013	0.01	0	45.6	40.4	71.8	140	127	0	34	33	34
2025	4	16	8	22	55	0.81	-0.079	3.799	0.01	0.007	0	45.2	40.4	65.4	139	126	0	34	32	33
2025	4	16	8	32	55	0.807	-0.098	3.799	0.013	0.01	0	46	41.3	70.5	141	128	0	34	32	34
2025	4	16	8	42	55	0.787	-0.049	3.799	0.01	0.007	0	46.4	40.9	71	141	128	0	33	33	33
2025	4	16	8	52	55	0.823	-0.089	3.799	0.01	0.007	0	46	40.9	70.5	141	128	0	34	33	33
2025	4	16	9	2	55	0.814	-0.105	3.799	0.013	0.01	0	46	40.4	71	141	128	0	34	34	33
2025	4	16	9	12	55	0.791	-0.072	3.799	0.013	0.01	0	46	41.3	70.1	141	128	0	34	32	34
2025	4	16	9	22	55	0.837	-0.092	3.802	0.013	0.01	0	46	40.9	57.2	141	128	0	34	33	34
2025	4	16	9	32	55	0.801	-0.079	3.802	0.01	0.007	0	45.6	40.9	65.8	140	127	0	34	32	34
2025	4	16	9	42	55	0.787	-0.066	3.802	0.013	0.01	0	46	40.4	72.2	141	127	0	34	33	33
2025	4	16	9	52	55	0.787	-0.059	3.802	0.016	0.013	0	45.6	40.4	73.5	140	126	0	34	32	33
2025	4	16	10	2	55	0.814	-0.105	3.802	0.01	0.007	0	45.6	40.9	71.4	140	127	0	34	32	33
2025	4	16	10	12	55	0.81	-0.105	3.802	0.01	0.007	0	45.6	40.4	73.5	140	126	0	34	32	34
2025	4	16	10	22	55	0.823	-0.112	3.802	0.01	0.007	0	44.7	39.6	74.8	138	125	0	34	33	33
2025	4	16	10	32	55	0.801	-0.089	3.802	0.01	0.007	0	45.2	40	74	139	126	0	34	33	33
2025	4	16	10	42	55	0.804	-0.089	3.806	0.01	0.007	0	44.7	40	74.4	138	125	0	34	32	34
2025	4	16	10	52	55	0.846	-0.062	3.802	0.01	0.007	0	45.2	40.4	73.1	139	126	0	34	32	34
2025	4	16	11	2	55	0.84	-0.095	3.806	0.01	0.007	0	44.3	40.4	75.3	137	125	0	34	31	33
2025	4	16	11	12	55	0.797	-0.089	3.806	0.016	0.013	0	44.7	40	75.7	138	125	0	34	32	33
2025	4	16	11	22	55	0.787	-0.072	3.806	0.013	0.01	0	45.2	40	74.8	138	125	0	33	32	33
2025	4	16	11	32	55	0.869	-0.108	3.806	0.01	0.007	0	44.7	39.6	74.4	138	125	0	34	33	33
2025	4	16	11	42	55	0.86	-0.121	3.806	0.013	0.01	0	44.7	39.6	73.5	138	125	0	34	33	34
2025	4	16	11	52	55	0.817	-0.112	3.806	0.01	0.007	0	44.7	38.7	75.3	138	122	0	34	32	33
2025	4	16	12	2	55	0.846	-0.115	3.806	0.01	0.007	0	45.2	39.6	63.6	138	125	0	33	33	33
2025	4	16	12	12	55	0.846	-0.112	3.806	0.01	0.007	0	45.2	40	54.6	138	125	0	33	32	33
2025	4	16	12	22	55	0.833	-0.098	3.806	0.01	0.007	0	45.2	40	74	138	125	0	33	32	33
2025	4	16	12	32	55	0.82	-0.098	3.806	0.013	0.01	0	44.7	40	70.5	138	125	0	34	32	33
2025	4	16	12	42	55	0.817	-0.098	3.802	0.013	0.01	0	44.3	39.1	49.9	137	124	0	34	33	33
2025	4	16	12	52	55	0.817	-0.105	3.806	0.013	0.01	0	44.7	39.6	74	137	124	0	33	32	33
2025	4	16	13	2	55	0.778	-0.066	3.806	0.013	0.01	0	45.6	40.9	58	140	127	0	34	32	33
2025	4	16	13	12	55	0.823	-0.102	3.806	0.01	0.007	0	44.7	40	61.9	138	125	0	34	32	33
2025	4	16	13	22	55	0.82	-0.112	3.802	0.013	0.01	0	45.2	40	49	138	125	0	33	32	33
2025	4	16	13	32	55	0.823	-0.095	3.806	0.016	0.013	0	45.2	40.4	48.6	139	126	0	34	32	33
2025	4	16	13	42	55	0.768	-0.092	3.802	0.01	0.007	0	45.2	40.4	49.9	139	126	0	34	32	33
2025	4	16	13	52	55	0.807	-0.092	3.802	0.01	0.007	0	45.6	40.4	49	139	126	0	33	32	33
2025	4	16	14	2	55	0.778	-0.131	3.802	0.016	0.013	0	44.7	40.4	48.2	138	126	0	34	32	33
2025	4	16	14	12	55	0.82	-0.135	3.809	0.016	0.013	0	45.2	40.9	46.9	139	127	0	34	32	34
2025	4	16	14	22	55	0.823	-0.059	3.806	0.013	0.01	0	46	40.9	48.6	140	127	0	33	32	33
2025	4	16	14	32	55	0.778	-0.066	3.799	0.01	0.007	0	45.6	40.4	48.2	140	127	0	34	33	33
2025	4	16	14	42	55	0.823	-0.069	3.802	0.016	0.013	0	45.6	41.3	49	140	128	0	34	32	33
2025	4	16	14	52	55	0.797	-0.092	3.806	0.01	0.007	0	45.2	40.9	49.5	140	127	0	35	32	33
2025	4	16	15	2	55	0.827	-0.089	3.802	0.013	0.01	0	45.6	40.4	48.6	140	127	0	34	33	33
2025	4	16	15	12	55	0.784	-0.075	3.802	0.013	0.01	0	45.6	40.9	51.2	140	127	0	34	32	32
2025	4	16	15	22	55	0.804	-0.102	3.802	0.016	0.016	0	45.2	40	50.7	139	126	0	34	33	33
2025	4	16	15	32	55	0.801	-0.092	3.802	0.013	0.01	0	44.7	40	48.2	138	125	0	34	32	33
2025	4	16	15	42	55	0.807	-0.095	3.802	0.01	0.007	0	44.7	40	46.4	138	125	0	34	32	33
2025	4	16	15	52	55	0.794	-0.066	3.802	0.013	0.01	0	44.7	39.6	47.7	138	124	0	34	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	16	16	2	55	0.82	-0.059	3.799	0.01	0.007	0	44.7	40	46.9	138	125	0	34	32	33
2025	4	16	16	12	55	0.85	-0.092	3.799	0.01	0.007	0	44.7	40	47.7	138	125	0	34	32	33
2025	4	16	16	22	55	0.846	-0.089	3.802	0.01	0.007	0	44.7	40	48.2	138	125	0	34	32	34
2025	4	16	16	32	55	0.801	-0.043	3.799	0.013	0.01	0	45.2	39.6	48.6	138	124	0	33	32	33
2025	4	16	16	42	55	0.833	-0.105	3.799	0.01	0.007	0	44.3	39.6	47.7	137	124	0	34	32	33
2025	4	16	16	52	55	0.827	-0.105	3.796	0.01	0.007	0	45.2	40.4	48.6	139	126	0	34	32	33
2025	4	16	17	2	55	0.804	-0.118	3.796	0.013	0.01	0	45.2	40.4	47.3	139	126	0	34	32	33
2025	4	16	17	12	55	0.804	-0.085	3.799	0.01	0.007	0	45.6	40.4	49.5	139	126	0	33	32	32
2025	4	16	17	22	55	0.82	-0.095	3.799	0.016	0.016	0	45.6	40.4	45.6	139	126	0	33	32	33
2025	4	16	17	32	55	0.787	-0.075	3.799	0.013	0.01	0	45.6	40.4	49	140	127	0	34	33	33
2025	4	16	17	42	55	0.827	-0.092	3.796	0.01	0.007	0	46.4	41.3	49.5	141	128	0	33	32	33
2025	4	16	17	52	55	0.797	-0.052	3.799	0.016	0.013	0	46	41.3	55.9	141	128	0	34	32	33
2025	4	16	18	2	55	0.85	-0.102	3.802	0.016	0.013	0	46	40.9	74.8	141	127	0	34	32	33
2025	4	16	18	12	55	0.863	-0.089	3.802	0.013	0.01	0	46	41.3	74	141	128	0	34	32	34
2025	4	16	18	22	55	0.804	-0.085	3.799	0.01	0.007	0	46	41.3	65.4	141	128	0	34	32	33
2025	4	16	18	32	55	0.843	-0.098	3.802	0.013	0.01	0	46	41.3	74.4	141	128	0	34	32	32
2025	4	16	18	42	55	0.837	-0.098	3.802	0.013	0.01	0	46.4	40.9	74.4	141	128	0	33	33	33
2025	4	16	18	52	55	0.846	-0.069	3.799	0.013	0.01	0	46.9	41.7	73.1	142	129	0	33	32	33
2025	4	16	19	2	55	0.827	-0.098	3.799	0.016	0.013	0	46.9	42.6	73.5	143	130	0	34	31	33
2025	4	16	19	12	55	0.863	-0.089	3.799	0.01	0.007	0	46.9	41.7	73.5	143	130	0	34	33	33
2025	4	16	19	22	55	0.784	-0.072	3.799	0.013	0.01	0	47.7	42.6	73.5	145	131	0	34	32	33
2025	4	16	19	32	55	0.81	-0.098	3.799	0.013	0.01	0	47.3	42.1	74	144	130	0	34	32	33
2025	4	16	19	42	55	0.85	-0.105	3.799	0.013	0.01	0	48.2	42.6	74	145	130	0	33	31	33
2025	4	16	19	52	55	0.843	-0.108	3.799	0.016	0.016	0	47.7	42.6	73.5	145	131	0	34	32	33
2025	4	16	20	2	55	0.86	-0.102	3.799	0.013	0.01	0	47.3	42.1	73.5	144	130	0	34	32	33
2025	4	16	20	12	55	0.84	-0.069	3.799	0.013	0.01	0	47.7	42.1	73.1	145	131	0	34	33	33
2025	4	16	20	22	55	0.807	-0.089	3.799	0.01	0.007	0	47.3	41.7	73.1	144	130	0	34	33	33
2025	4	16	20	32	55	0.86	-0.079	3.799	0.016	0.013	0	47.3	41.7	74.4	144	130	0	34	33	33
2025	4	16	20	42	55	0.853	-0.082	3.799	0.01	0.007	0	47.3	42.1	73.1	144	130	0	34	32	34
2025	4	16	20	52	55	0.837	-0.089	3.799	0.01	0.007	0	47.7	42.1	73.5	145	131	0	34	33	33
2025	4	16	21	2	55	0.84	-0.092	3.796	0.016	0.013	0	47.3	42.6	73.5	144	131	0	34	32	33
2025	4	16	21	12	55	0.794	-0.075	3.799	0.01	0.007	0	47.3	42.6	74	144	131	0	34	32	33
2025	4	16	21	22	55	0.83	-0.092	3.796	0.013	0.01	0	47.3	41.7	73.5	144	130	0	34	33	34
2025	4	16	21	32	55	0.843	-0.079	3.796	0.016	0.013	0	46.9	41.7	74.4	143	130	0	34	33	33
2025	4	16	21	42	55	0.804	-0.082	3.796	0.01	0.007	0	46.9	41.7	74.4	143	130	0	34	33	32
2025	4	16	21	52	55	0.827	-0.095	3.796	0.01	0.007	0	46.9	41.7	73.5	143	130	0	34	33	34
2025	4	16	22	2	55	0.85	-0.089	3.796	0.016	0.013	0	46.9	41.3	73.1	143	129	0	34	33	33
2025	4	16	22	12	55	0.833	-0.105	3.796	0.016	0.013	0	46.9	41.7	74	143	129	0	34	32	33
2025	4	16	22	22	55	0.856	-0.098	3.796	0.01	0.007	0	47.3	41.7	74	144	130	0	34	33	33
2025	4	16	22	32	55	0.84	-0.108	3.796	0.013	0.01	0	46.9	41.3	73.5	143	129	0	34	33	33
2025	4	16	22	42	55	0.814	-0.075	3.796	0.013	0.01	0	47.7	41.3	74	144	129	0	33	33	33
2025	4	16	22	52	55	0.846	-0.102	3.796	0.01	0.007	0	47.3	41.7	73.5	144	130	0	34	33	33
2025	4	16	23	2	55	0.823	-0.102	3.796	0.01	0.007	0	47.7	42.6	72.7	144	130	0	33	31	34
2025	4	16	23	12	55	0.814	-0.089	3.796	0.01	0.007	0	47.3	41.7	74	144	130	0	34	33	33
2025	4	16	23	22	55	0.81	-0.128	3.793	0.016	0.013	0	46.9	41.3	73.5	143	129	0	34	33	34
2025	4	16	23	32	55	0.837	-0.112	3.796	0.016	0.013	0	46.9	41.7	73.1	143	129	0	34	32	33
2025	4	16	23	42	55	0.827	-0.102	3.793	0.013	0.01	0	46.9	41.3	73.5	143	129	0	34	33	34
2025	4	16	23	52	55	0.82	-0.105	3.793	0.016	0.013	0	46.9	41.7	74	143	129	0	34	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	17	0	2	55	0.801	-0.141	3.793	0.01	0.007	0	46.9	41.3	74	142	129	0	33	33	33
2025	4	17	0	12	55	0.817	-0.082	3.793	0.013	0.01	0	46.9	40.9	74	143	128	0	34	33	33
2025	4	17	0	22	55	0.833	-0.089	3.793	0.01	0.007	0	46.4	40.9	74.4	142	128	0	34	33	33
2025	4	17	0	32	55	0.879	-0.085	3.793	0.01	0.007	0	46.4	41.3	73.5	142	129	0	34	33	34
2025	4	17	0	42	55	0.817	-0.108	3.793	0.01	0.007	0	46.4	41.7	73.1	142	129	0	34	32	34
2025	4	17	0	52	55	0.837	-0.075	3.793	0.01	0.007	0	46.9	41.7	74	143	129	0	34	32	34
2025	4	17	1	2	55	0.84	-0.115	3.793	0.013	0.01	0	47.3	41.7	74.4	143	129	0	33	32	33
2025	4	17	1	12	55	0.823	-0.135	3.793	0.016	0.013	0	47.3	41.7	74.8	143	129	0	33	32	32
2025	4	17	1	22	55	0.814	-0.098	3.793	0.01	0.007	0	46.4	41.3	74	142	128	0	34	32	34
2025	4	17	1	32	55	0.833	-0.102	3.793	0.016	0.013	0	46.9	41.3	74	143	129	0	34	33	34
2025	4	17	1	42	55	0.843	-0.085	3.793	0.01	0.007	0	46.4	41.7	73.5	143	129	0	35	32	34
2025	4	17	1	52	55	0.846	-0.085	3.793	0.016	0.013	0	46.9	41.3	74	143	129	0	34	33	33
2025	4	17	2	2	55	0.879	-0.102	3.793	0.013	0.01	0	46.9	41.3	73.1	143	129	0	34	33	34
2025	4	17	2	12	55	0.817	-0.079	3.793	0.013	0.01	0	46.9	41.3	74	143	129	0	34	33	34
2025	4	17	2	22	55	0.853	-0.102	3.793	0.013	0.01	0	46.9	41.3	74.4	143	129	0	34	33	33
2025	4	17	2	32	55	0.873	-0.082	3.793	0.016	0.013	0	46.9	41.7	74.4	143	129	0	34	32	33
2025	4	17	2	42	55	0.817	-0.089	3.793	0.01	0.007	0	46.9	41.7	74	143	129	0	34	32	33
2025	4	17	2	52	55	0.86	-0.105	3.793	0.01	0.007	0	46.4	41.7	74	142	129	0	34	32	33
2025	4	17	3	2	55	0.827	-0.079	3.793	0.01	0.007	0	46.9	41.3	74	143	129	0	34	33	34
2025	4	17	3	12	55	0.833	-0.121	3.793	0.016	0.013	0	46.4	41.3	74.4	142	129	0	34	33	34
2025	4	17	3	22	55	0.863	-0.118	3.793	0.016	0.013	0	46.9	41.3	73.5	143	129	0	34	33	34
2025	4	17	3	32	55	0.833	-0.135	3.793	0.013	0.01	0	46.4	41.3	73.1	142	129	0	34	33	34
2025	4	17	3	42	55	0.833	-0.102	3.793	0.013	0.01	0	46.9	41.7	74	143	130	0	34	33	33
2025	4	17	3	52	55	0.846	-0.092	3.793	0.013	0.01	0	46.9	41.7	74	143	129	0	34	32	34
2025	4	17	4	2	55	0.85	-0.105	3.793	0.01	0.007	0	46.4	41.3	74.4	142	129	0	34	33	33
2025	4	17	4	12	55	0.804	-0.089	3.793	0.016	0.013	0	46.4	41.3	73.1	142	129	0	34	33	33
2025	4	17	4	22	55	0.814	-0.108	3.793	0.01	0.007	0	46.9	41.3	73.1	142	129	0	33	33	34
2025	4	17	4	32	55	0.807	-0.092	3.793	0.013	0.01	0	46.9	41.7	73.5	143	130	0	34	33	34
2025	4	17	4	42	55	0.833	-0.108	3.793	0.01	0.007	0	46.4	41.7	74	142	129	0	34	32	34
2025	4	17	4	52	55	0.804	-0.108	3.793	0.013	0.01	0	46.4	41.7	74	142	129	0	34	32	33
2025	4	17	5	2	55	0.82	-0.089	3.793	0.013	0.01	0	46.4	41.3	73.5	142	129	0	34	33	34
2025	4	17	5	12	55	0.84	-0.108	3.793	0.013	0.01	0	46	40.9	74	141	128	0	34	33	33
2025	4	17	5	22	55	0.833	-0.095	3.793	0.016	0.013	0	46	41.3	74	141	128	0	34	32	34
2025	4	17	5	32	55	0.817	-0.108	3.793	0.016	0.016	0	46.4	40.9	74	141	128	0	33	33	34
2025	4	17	5	42	55	0.846	-0.092	3.793	0.016	0.013	0	46	40.4	74.4	140	127	0	33	33	34
2025	4	17	5	52	55	0.817	-0.079	3.793	0.013	0.01	0	45.6	40.9	74.4	140	127	0	34	32	34
2025	4	17	6	2	55	0.781	-0.059	3.793	0.016	0.013	0	45.2	40.4	74.4	139	126	0	34	32	34
2025	4	17	6	12	55	0.823	-0.125	3.793	0.013	0.01	0	44.7	40	74.4	138	125	0	34	32	34
2025	4	17	6	22	55	0.866	-0.118	3.793	0.01	0.007	0	44.3	39.6	74.4	137	124	0	34	32	33
2025	4	17	6	32	55	0.83	-0.102	3.793	0.01	0.007	0	43.9	39.1	62.4	136	123	0	34	32	33
2025	4	17	6	42	55	0.814	-0.105	3.793	0.013	0.01	0	43.9	38.7	65.4	136	123	0	34	33	33
2025	4	17	6	52	55	0.81	-0.121	3.793	0.013	0.01	0	43.9	39.1	55.5	136	124	0	34	33	34
2025	4	17	7	2	55	0.84	-0.131	3.793	0.01	0.007	0	43.9	38.7	72.2	136	123	0	34	33	33
2025	4	17	7	12	55	0.833	-0.092	3.793	0.013	0.01	0	44.3	39.1	53.3	137	124	0	34	33	33
2025	4	17	7	22	55	0.784	-0.069	3.793	0.01	0.007	0	44.7	39.6	52	137	125	0	33	33	34
2025	4	17	7	32	55	0.84	-0.102	3.793	0.013	0.01	0	44.3	39.6	58	137	124	0	34	32	33
2025	4	17	7	42	55	0.82	-0.098	3.793	0.013	0.01	0	44.7	39.6	67.9	138	125	0	34	33	33
2025	4	17	7	52	55	0.814	-0.131	3.796	0.01	0.007	0	44.7	39.6	75.3	138	125	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	17	8	2	55	0.843	-0.079	3.796	0.013	0.01	0	44.3	39.1	74.4	137	125	0	34	34	34
2025	4	17	8	12	55	0.81	-0.095	3.796	0.01	0.007	0	44.3	39.6	75.7	138	125	0	35	33	33
2025	4	17	8	22	55	0.873	-0.085	3.796	0.01	0.007	0	45.2	40.9	75.3	139	127	0	34	32	33
2025	4	17	8	32	55	0.827	-0.095	3.796	0.01	0.007	0	44.7	40.4	75.7	138	126	0	34	32	33
2025	4	17	8	42	55	0.801	-0.095	3.796	0.01	0.007	0	45.2	40	75.3	139	126	0	34	33	34
2025	4	17	8	52	55	0.823	-0.092	3.796	0.016	0.016	0	45.2	40.4	75.3	139	127	0	34	33	33
2025	4	17	9	2	55	0.807	-0.085	3.796	0.01	0.007	0	45.6	40.9	75.3	140	127	0	34	32	33
2025	4	17	9	12	55	0.85	-0.079	3.799	0.01	0.007	0	46	40.9	74.8	141	128	0	34	33	34
2025	4	17	9	22	55	0.837	-0.115	3.799	0.013	0.01	0	45.2	40.9	74.8	139	127	0	34	32	33
2025	4	17	9	32	55	0.804	-0.082	3.799	0.01	0.007	0	45.2	41.3	75.3	139	128	0	34	32	33
2025	4	17	9	42	55	0.82	-0.092	3.799	0.01	0.007	0	46	41.3	74	140	128	0	33	32	34
2025	4	17	9	52	55	0.856	-0.105	3.799	0.01	0.007	0	46	40.4	73.5	140	127	0	33	33	33
2025	4	17	10	2	55	0.837	-0.092	3.799	0.01	0.007	0	45.6	41.7	74.4	140	128	0	34	31	33
2025	4	17	10	12	55	0.843	-0.108	3.799	0.016	0.013	0	46	41.3	74	141	129	0	34	33	33
2025	4	17	10	22	55	0.827	-0.089	3.799	0.01	0.007	0	46	41.3	74.4	141	129	0	34	33	34
2025	4	17	10	32	55	0.84	-0.112	3.799	0.016	0.013	0	45.6	40.9	74	140	128	0	34	33	34
2025	4	17	10	42	55	0.814	-0.089	3.799	0.016	0.013	0	45.2	40.4	74.8	139	127	0	34	33	33
2025	4	17	10	52	55	0.807	-0.089	3.799	0.013	0.01	0	44.7	40	74.4	138	126	0	34	33	33
2025	4	17	11	2	55	0.833	-0.102	3.802	0.01	0.007	0	45.2	40.4	74	139	127	0	34	33	34
2025	4	17	11	12	55	0.807	-0.079	3.802	0.01	0.007	0	44.7	40.4	73.1	138	126	0	34	32	34
2025	4	17	11	22	55	0.778	-0.089	3.802	0.016	0.016	0	44.7	40.4	74.8	138	126	0	34	32	33
2025	4	17	11	32	55	0.843	-0.082	3.802	0.013	0.01	0	44.7	40	75.3	138	125	0	34	32	32
2025	4	17	11	42	55	0.804	-0.066	3.802	0.01	0.007	0	44.3	40	72.7	137	125	0	34	32	33
2025	4	17	11	52	55	0.833	-0.062	3.802	0.013	0.01	0	44.7	40	73.1	137	125	0	33	32	33
2025	4	17	12	2	55	0.814	-0.059	3.802	0.01	0.007	0	44.7	40	73.5	138	125	0	34	32	32
2025	4	17	12	12	55	0.83	-0.085	3.802	0.01	0.007	0	44.3	40	73.5	137	125	0	34	32	33
2025	4	17	12	22	55	0.83	-0.079	3.802	0.013	0.01	0	45.6	40.9	74	139	127	0	33	32	33
2025	4	17	12	32	55	0.814	-0.085	3.802	0.016	0.013	0	45.2	40.9	70.5	139	127	0	34	32	32
2025	4	17	12	42	55	0.827	-0.082	3.802	0.016	0.013	0	44.7	40.4	68.8	138	126	0	34	32	33
2025	4	17	12	52	55	0.823	-0.095	3.799	0.013	0.01	0	45.2	40.4	54.2	138	126	0	33	32	33
2025	4	17	13	2	55	0.843	-0.046	3.799	0.013	0.01	0	45.2	40.9	50.3	138	127	0	33	32	34
2025	4	17	13	12	55	0.81	-0.089	3.799	0.016	0.013	0	44.7	40.4	50.3	138	126	0	34	32	33
2025	4	17	13	22	55	0.817	-0.092	3.799	0.016	0.013	0	45.6	40.9	52.5	139	127	0	33	32	33
2025	4	17	13	32	55	0.781	-0.085	3.799	0.013	0.01	0	44.3	40.4	49	137	126	0	34	32	33
2025	4	17	13	42	55	0.823	-0.092	3.799	0.013	0.01	0	44.7	39.6	45.6	137	124	0	33	32	34
2025	4	17	13	52	55	0.85	-0.118	3.799	0.01	0.007	0	44.3	39.6	49.9	136	124	0	33	32	33
2025	4	17	14	2	55	0.814	-0.112	3.799	0.01	0.007	0	44.7	40	47.7	138	125	0	34	32	33
2025	4	17	14	12	55	0.791	-0.075	3.799	0.01	0.007	0	44.3	40	48.6	137	125	0	34	32	33
2025	4	17	14	22	55	0.794	-0.066	3.799	0.016	0.013	0	45.2	40	46	139	126	0	34	33	33
2025	4	17	14	32	55	0.83	-0.095	3.799	0.013	0.01	0	45.2	40.4	47.7	138	126	0	33	32	34
2025	4	17	14	42	55	0.797	-0.085	3.793	0.016	0.013	0	45.2	40.9	49	139	127	0	34	32	33
2025	4	17	14	52	55	0.83	-0.095	3.796	0.013	0.01	0	45.2	41.3	47.3	139	128	0	34	32	33
2025	4	17	15	2	55	0.823	-0.102	3.796	0.01	0.007	0	46	40.9	49	140	128	0	33	33	33
2025	4	17	15	12	55	0.774	-0.092	3.796	0.01	0.007	0	45.2	41.3	47.3	139	128	0	34	32	34
2025	4	17	15	22	55	0.787	-0.079	3.796	0.01	0.007	0	45.2	40.9	48.6	139	127	0	34	32	33
2025	4	17	15	32	55	0.807	-0.085	3.802	0.013	0.01	0	45.2	40.4	50.7	139	127	0	34	33	33
2025	4	17	15	42	55	0.82	-0.079	3.796	0.01	0.007	0	45.6	42.1	48.2	140	129	0	34	31	33
2025	4	17	15	52	55	0.82	-0.062	3.796	0.01	0.007	0	46	40.9	48.6	140	128	0	33	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	17	16	2	55	0.794	-0.043	3.793	0.013	0.01	0	45.6	41.7	49.9	140	129	0	34	32	33
2025	4	17	16	12	55	0.85	-0.075	3.796	0.016	0.013	0	45.2	41.3	46.4	139	128	0	34	32	33
2025	4	17	16	22	55	0.837	-0.075	3.799	0.01	0.007	0	45.2	41.3	48.2	139	128	0	34	32	33
2025	4	17	16	32	55	0.823	-0.098	3.793	0.013	0.01	0	43.9	40.9	48.2	136	127	0	34	32	33
2025	4	17	16	42	55	0.807	-0.085	3.793	0.01	0.007	0	44.7	40	49	138	126	0	34	33	33
2025	4	17	16	52	55	0.814	-0.069	3.796	0.013	0.01	0	44.3	40	47.7	137	126	0	34	33	33
2025	4	17	17	2	55	0.827	-0.075	3.793	0.016	0.013	0	44.3	40	49.9	137	125	0	34	32	33
2025	4	17	17	12	55	0.787	-0.089	3.793	0.01	0.007	0	44.3	40	49.9	138	125	0	35	32	34
2025	4	17	17	22	55	0.787	-0.075	3.796	0.01	0.007	0	44.3	39.6	47.3	137	125	0	34	33	33
2025	4	17	17	32	55	0.807	-0.075	3.793	0.01	0.007	0	44.3	39.6	49.5	137	125	0	34	33	33
2025	4	17	17	42	55	0.823	-0.062	3.793	0.016	0.013	0	45.2	40	50.7	138	126	0	33	33	33
2025	4	17	17	52	55	0.846	-0.069	3.796	0.013	0.01	0	44.3	40.4	57.2	137	126	0	34	32	33
2025	4	17	18	2	55	0.804	-0.085	3.793	0.01	0.007	0	44.7	40	59.8	138	126	0	34	33	33
2025	4	17	18	12	55	0.83	-0.079	3.796	0.013	0.01	0	44.7	40.4	68.8	138	126	0	34	32	33
2025	4	17	18	22	55	0.817	-0.069	3.796	0.013	0.01	0	44.7	40	69.7	138	126	0	34	33	33
2025	4	17	18	32	55	0.846	-0.098	3.796	0.013	0.01	0	44.7	40.9	72.7	138	127	0	34	32	33
2025	4	17	18	42	55	0.833	-0.102	3.796	0.013	0.01	0	45.2	41.3	71.4	139	128	0	34	32	33
2025	4	17	18	52	55	0.82	-0.092	3.796	0.01	0.007	0	45.6	40.9	71.4	140	128	0	34	33	33
2025	4	17	19	2	55	0.807	-0.095	3.793	0.016	0.013	0	46.4	41.3	55.9	142	129	0	34	33	33
2025	4	17	19	12	55	0.846	-0.059	3.796	0.013	0.01	0	46	41.7	70.5	141	129	0	34	32	34
2025	4	17	19	22	55	0.823	-0.095	3.796	0.016	0.013	0	46.4	42.1	72.2	142	130	0	34	32	33
2025	4	17	19	32	55	0.82	-0.089	3.796	0.013	0.01	0	46.4	41.7	72.2	142	129	0	34	32	33
2025	4	17	19	42	55	0.797	-0.075	3.796	0.016	0.016	0	46.9	42.1	72.2	143	131	0	34	33	33
2025	4	17	19	52	55	0.869	-0.121	3.793	0.01	0.007	0	46.9	41.7	72.7	142	130	0	33	33	33
2025	4	17	20	2	55	0.817	-0.062	3.793	0.016	0.013	0	46.9	41.7	72.2	142	130	0	33	33	33
2025	4	17	20	12	55	0.823	-0.098	3.793	0.01	0.007	0	46.4	41.7	72.2	142	130	0	34	33	34
2025	4	17	20	22	55	0.846	-0.108	3.793	0.013	0.01	0	46	41.7	72.7	141	129	0	34	32	33
2025	4	17	20	32	55	0.827	-0.105	3.793	0.01	0.007	0	46.4	41.7	63.6	141	129	0	33	32	33
2025	4	17	20	42	55	0.823	-0.075	3.793	0.01	0.007	0	46	41.3	72.7	141	129	0	34	33	34
2025	4	17	20	52	55	0.883	-0.115	3.793	0.013	0.01	0	46	41.3	73.1	141	129	0	34	33	33
2025	4	17	21	2	55	0.86	-0.128	3.793	0.013	0.01	0	45.6	41.3	73.1	140	129	0	34	33	33
2025	4	17	21	12	55	0.85	-0.118	3.789	0.013	0.01	0	46.9	41.3	72.7	143	128	0	34	32	33
2025	4	17	21	22	55	0.82	-0.092	3.793	0.013	0.01	0	47.3	41.3	73.5	144	129	0	34	33	33
2025	4	17	21	32	55	0.833	-0.089	3.789	0.01	0.007	0	47.7	42.1	66.7	145	130	0	34	32	34
2025	4	17	21	42	55	0.853	-0.072	3.789	0.013	0.01	0	47.3	41.3	72.7	144	129	0	34	33	33
2025	4	17	21	52	55	0.843	-0.043	3.789	0.01	0.007	0	47.3	41.3	72.7	144	129	0	34	33	34
2025	4	17	22	2	55	0.804	-0.138	3.789	0.01	0.007	0	46.9	40.9	72.2	143	128	0	34	33	34
2025	4	17	22	12	55	0.833	-0.075	3.789	0.016	0.013	0	47.3	40.9	58	143	128	0	33	33	34
2025	4	17	22	22	55	0.774	-0.075	3.786	0.01	0.007	0	47.3	42.1	69.2	144	130	0	34	32	34
2025	4	17	22	32	55	0.833	-0.089	3.786	0.01	0.007	0	47.3	41.3	71.4	144	129	0	34	33	33
2025	4	17	22	42	55	0.814	-0.082	3.786	0.016	0.013	0	47.3	41.7	72.2	144	130	0	34	33	33
2025	4	17	22	52	55	0.84	-0.102	3.789	0.013	0.01	0	46.9	40.9	72.2	143	128	0	34	33	34
2025	4	17	23	2	55	0.82	-0.102	3.786	0.01	0.007	0	46.9	41.3	73.5	143	129	0	34	33	33
2025	4	17	23	12	55	0.817	-0.105	3.786	0.013	0.01	0	46.9	41.3	73.5	143	129	0	34	33	33
2025	4	17	23	22	55	0.801	-0.095	3.786	0.01	0.007	0	46.9	41.3	72.7	143	129	0	34	33	33
2025	4	17	23	32	55	0.83	-0.082	3.786	0.013	0.01	0	46.4	41.3	73.1	142	128	0	34	32	34
2025	4	17	23	42	55	0.837	-0.095	3.786	0.013	0.01	0	46.4	41.3	73.5	142	128	0	34	32	33
2025	4	17	23	52	55	0.781	-0.092	3.786	0.013	0.01	0	46.9	41.7	72.7	143	129	0	34	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	18	0	2	55	0.807	-0.075	3.786	0.016	0.013	0	46.4	41.3	73.1	142	129	0	34	33	33
2025	4	18	0	12	55	0.866	-0.092	3.786	0.013	0.01	0	46.4	41.3	73.1	142	129	0	34	33	33
2025	4	18	0	22	55	0.814	-0.098	3.786	0.01	0.007	0	46.9	41.7	72.7	143	129	0	34	32	33
2025	4	18	0	32	55	0.814	-0.092	3.786	0.013	0.01	0	46	41.3	73.1	142	128	0	35	32	33
2025	4	18	0	42	55	0.817	-0.092	3.786	0.01	0.007	0	46.4	40.4	73.1	142	128	0	34	34	33
2025	4	18	0	52	55	0.853	-0.105	3.786	0.013	0.01	0	46.4	40.9	73.1	142	128	0	34	33	33
2025	4	18	1	2	55	0.817	-0.072	3.786	0.01	0.007	0	46.4	41.7	72.2	142	129	0	34	32	34
2025	4	18	1	12	55	0.794	-0.095	3.786	0.013	0.01	0	46.4	41.3	72.2	142	129	0	34	33	34
2025	4	18	1	22	55	0.83	-0.092	3.783	0.013	0.01	0	46.4	40.9	71.4	142	128	0	34	33	34
2025	4	18	1	32	55	0.814	-0.092	3.783	0.016	0.013	0	46.4	40.9	72.2	142	128	0	34	33	34
2025	4	18	1	42	55	0.778	-0.102	3.783	0.013	0.01	0	46.4	40.9	73.1	142	128	0	34	33	33
2025	4	18	1	52	55	0.843	-0.069	3.783	0.01	0.007	0	46.4	41.3	73.1	142	128	0	34	32	33
2025	4	18	2	2	55	0.791	-0.072	3.783	0.01	0.007	0	46	40.9	72.7	142	128	0	35	33	33
2025	4	18	2	12	55	0.83	-0.089	3.783	0.013	0.01	0	46.4	40.9	72.7	142	128	0	34	33	33
2025	4	18	2	22	55	0.843	-0.092	3.783	0.01	0.007	0	46.4	40.9	72.7	142	128	0	34	33	33
2025	4	18	2	32	55	0.833	-0.115	3.783	0.013	0.01	0	46.4	40.9	72.2	142	128	0	34	33	34
2025	4	18	2	42	55	0.833	-0.098	3.783	0.013	0.01	0	46.4	40.9	72.7	142	128	0	34	33	34
2025	4	18	2	52	55	0.883	-0.115	3.783	0.013	0.01	0	46	41.3	73.5	141	128	0	34	32	33
2025	4	18	3	2	55	0.801	-0.075	3.783	0.01	0.007	0	46.4	41.3	73.1	142	128	0	34	32	33
2025	4	18	3	12	55	0.804	-0.069	3.783	0.013	0.01	0	46.4	40.9	72.7	142	128	0	34	33	34
2025	4	18	3	22	55	0.814	-0.105	3.783	0.013	0.01	0	46.4	40.4	72.7	141	127	0	33	33	34
2025	4	18	3	32	55	0.82	-0.102	3.783	0.013	0.01	0	46	40.9	72.7	141	128	0	34	33	34
2025	4	18	3	42	55	0.83	-0.085	3.783	0.013	0.01	0	45.6	40.9	72.7	141	128	0	35	33	34
2025	4	18	3	52	55	0.853	-0.069	3.783	0.01	0.007	0	45.6	40.9	73.1	141	128	0	35	33	34
2025	4	18	4	2	55	0.856	-0.105	3.783	0.013	0.01	0	46	40.4	73.5	141	127	0	34	33	33
2025	4	18	4	12	55	0.784	-0.049	3.783	0.013	0.01	0	46.4	41.3	73.5	142	128	0	34	32	33
2025	4	18	4	22	55	0.817	-0.108	3.783	0.016	0.013	0	45.6	40.9	73.1	141	128	0	35	33	34
2025	4	18	4	32	55	0.833	-0.082	3.783	0.016	0.016	0	46	40.9	73.1	141	127	0	34	32	34
2025	4	18	4	42	55	0.827	-0.085	3.783	0.016	0.013	0	46	40.9	73.5	141	128	0	34	33	33
2025	4	18	4	52	55	0.817	-0.075	3.783	0.01	0.007	0	46	40.9	73.1	141	127	0	34	32	33
2025	4	18	5	2	55	0.82	-0.102	3.783	0.013	0.01	0	45.6	40.4	72.2	141	127	0	35	33	33
2025	4	18	5	12	55	0.794	-0.115	3.783	0.013	0.01	0	46	41.3	71.8	141	128	0	34	32	34
2025	4	18	5	22	55	0.84	-0.108	3.783	0.013	0.01	0	46	40.9	73.1	141	128	0	34	33	33
2025	4	18	5	32	55	0.869	-0.098	3.783	0.01	0.007	0	45.6	40	73.1	140	126	0	34	33	34
2025	4	18	5	42	55	0.814	-0.095	3.783	0.016	0.016	0	45.2	40	73.5	139	126	0	34	33	33
2025	4	18	5	52	55	0.83	-0.115	3.783	0.013	0.01	0	44.7	39.6	74.4	138	125	0	34	33	33
2025	4	18	6	2	55	0.84	-0.095	3.783	0.016	0.013	0	44.3	39.6	74	137	124	0	34	32	34
2025	4	18	6	12	55	0.794	-0.102	3.783	0.01	0.007	0	45.2	39.1	73.5	138	124	0	33	33	34
2025	4	18	6	22	55	0.82	-0.121	3.783	0.013	0.01	0	44.3	39.1	74	137	124	0	34	33	34
2025	4	18	6	32	55	0.86	-0.085	3.783	0.013	0.01	0	43.9	39.1	72.2	136	123	0	34	32	34
2025	4	18	6	42	55	0.804	-0.105	3.78	0.013	0.01	0	43.9	39.1	59.3	137	124	0	35	33	33
2025	4	18	6	52	55	0.82	-0.089	3.783	0.013	0.01	0	44.3	39.1	52.9	137	124	0	34	33	33
2025	4	18	7	2	55	0.797	-0.075	3.78	0.013	0.01	0	44.3	39.6	52.5	137	124	0	34	32	33
2025	4	18	7	12	55	0.81	-0.125	3.78	0.01	0.007	0	44.3	39.6	51.6	138	125	0	35	33	34
2025	4	18	7	22	55	0.797	-0.085	3.78	0.01	0.007	0	44.7	40	51.2	137	125	0	33	32	33
2025	4	18	7	32	55	0.797	-0.128	3.776	0.013	0.01	0	44.7	39.6	49	138	125	0	34	33	34
2025	4	18	7	42	55	0.84	-0.066	3.78	0.013	0.01	0	44.7	40.4	50.3	138	126	0	34	32	34
2025	4	18	7	52	55	0.801	-0.089	3.776	0.013	0.01	0	44.7	40	48.6	138	126	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	18	8	2	55	0.787	-0.079	3.78	0.01	0.007	0	45.2	40.4	49	139	127	0	34	33	34
2025	4	18	8	12	55	0.807	-0.108	3.776	0.013	0.01	0	45.6	40.9	49	139	127	0	33	32	34
2025	4	18	8	22	55	0.82	-0.102	3.776	0.016	0.016	0	45.6	40.4	49	140	127	0	34	33	34
2025	4	18	8	32	55	0.801	-0.135	3.776	0.013	0.01	0	45.2	40.9	49.5	139	128	0	34	33	34
2025	4	18	8	42	55	0.784	-0.092	3.776	0.013	0.01	0	45.6	40.4	48.6	140	127	0	34	33	34
2025	4	18	8	52	55	0.804	-0.105	3.776	0.01	0.007	0	45.6	40.9	49.5	140	128	0	34	33	34
2025	4	18	9	2	55	0.797	-0.098	3.776	0.01	0.007	0	45.6	40.9	49.5	140	127	0	34	32	34
2025	4	18	9	12	55	0.81	-0.118	3.776	0.013	0.01	0	44.7	40.4	50.7	139	126	0	35	32	34
2025	4	18	9	22	55	0.784	-0.102	3.776	0.016	0.016	0	44.3	39.6	50.7	137	125	0	34	33	34
2025	4	18	9	32	55	0.784	-0.075	3.776	0.013	0.01	0	44.7	39.6	49.5	138	125	0	34	33	33
2025	4	18	9	42	55	0.807	-0.089	3.776	0.013	0.01	0	44.3	40	51.2	137	125	0	34	32	33
2025	4	18	9	52	55	0.81	-0.069	3.773	0.013	0.01	0	44.3	39.6	52	137	125	0	34	33	33
2025	4	18	10	2	55	0.804	-0.085	3.773	0.01	0.007	0	43.9	39.1	49.9	136	124	0	34	33	34
2025	4	18	10	12	55	0.774	-0.075	3.773	0.013	0.01	0	44.3	39.1	51.6	137	124	0	34	33	33
2025	4	18	10	22	55	0.81	-0.069	3.773	0.01	0.007	0	44.3	39.1	50.7	137	124	0	34	33	33
2025	4	18	10	32	55	0.82	-0.092	3.773	0.013	0.01	0	43.9	39.1	50.3	136	124	0	34	33	34
2025	4	18	10	42	55	0.787	-0.089	3.773	0.016	0.013	0	43.9	39.1	49.5	136	124	0	34	33	33
2025	4	18	10	52	55	0.833	-0.092	3.773	0.013	0.01	0	43.9	39.1	51.6	136	124	0	34	33	33
2025	4	18	11	2	55	0.778	-0.095	3.77	0.01	0.007	0	44.3	39.6	52.5	136	124	0	33	32	34
2025	4	18	11	12	55	0.82	-0.072	3.773	0.016	0.013	0	43.9	39.6	50.7	136	124	0	34	32	34
2025	4	18	11	22	55	0.807	-0.089	3.77	0.01	0.007	0	43.9	39.1	53.8	136	124	0	34	33	33
2025	4	18	11	32	55	0.787	-0.046	3.773	0.016	0.013	0	44.7	40	52	137	125	0	33	32	33
2025	4	18	11	42	55	0.794	-0.151	3.773	0.013	0.01	0	44.3	39.6	52.5	137	125	0	34	33	33
2025	4	18	11	52	55	0.84	-0.092	3.773	0.013	0.01	0	43.9	39.6	52	136	124	0	34	32	33
2025	4	18	12	2	55	0.801	-0.095	3.773	0.013	0.01	0	43.9	39.1	51.6	136	124	0	34	33	34
2025	4	18	12	12	55	0.846	-0.115	3.773	0.01	0.007	0	44.3	39.1	49.9	137	124	0	34	33	34
2025	4	18	12	22	55	0.801	-0.089	3.773	0.01	0.007	0	44.7	39.6	51.6	137	125	0	33	33	34
2025	4	18	12	32	55	0.797	-0.089	3.77	0.01	0.007	0	44.3	40	52	137	125	0	34	32	34
2025	4	18	12	42	55	0.807	-0.112	3.77	0.016	0.013	0	43.9	39.1	50.7	136	124	0	34	33	34
2025	4	18	12	52	55	0.843	-0.102	3.773	0.01	0.007	0	44.3	40	52.5	137	125	0	34	32	33
2025	4	18	13	2	55	0.787	-0.082	3.773	0.01	0.007	0	43.9	39.6	51.6	136	125	0	34	33	33
2025	4	18	13	12	55	0.85	-0.072	3.773	0.013	0.01	0	44.3	39.6	51.2	137	125	0	34	33	33
2025	4	18	13	22	55	0.787	-0.089	3.773	0.013	0.01	0	43.4	39.1	49.9	136	124	0	35	33	34
2025	4	18	13	32	55	0.791	-0.112	3.773	0.013	0.01	0	44.3	39.6	51.6	137	125	0	34	33	33
2025	4	18	13	42	55	0.814	-0.082	3.776	0.013	0.01	0	44.7	40	51.2	138	126	0	34	33	33
2025	4	18	13	52	55	0.787	-0.082	3.77	0.01	0.007	0	44.3	39.6	52.5	137	125	0	34	33	34
2025	4	18	14	2	55	0.787	-0.105	3.773	0.013	0.01	0	44.7	39.6	51.6	137	125	0	33	33	33
2025	4	18	14	12	55	0.807	-0.075	3.773	0.01	0.007	0	44.3	39.6	52.5	137	125	0	34	33	33
2025	4	18	14	22	55	0.84	-0.085	3.776	0.013	0.01	0	43.9	39.1	51.2	136	124	0	34	33	33
2025	4	18	14	32	55	0.823	-0.115	3.773	0.013	0.01	0	44.3	39.6	49.9	137	125	0	34	33	33
2025	4	18	14	42	55	0.843	-0.112	3.773	0.01	0.007	0	44.3	40	51.2	137	125	0	34	32	33
2025	4	18	14	52	55	0.794	-0.079	3.776	0.013	0.01	0	44.3	40.4	49.9	137	126	0	34	32	34
2025	4	18	15	2	55	0.778	-0.082	3.773	0.013	0.01	0	44.7	40.4	50.7	138	126	0	34	32	33
2025	4	18	15	12	55	0.804	-0.075	3.773	0.013	0.01	0	44.7	40.4	51.2	138	126	0	34	32	33
2025	4	18	15	22	55	0.817	-0.095	3.773	0.013	0.01	0	44.3	40	50.7	137	125	0	34	32	34
2025	4	18	15	32	55	0.784	-0.075	3.773	0.013	0.01	0	45.2	40	49.9	138	126	0	33	33	34
2025	4	18	15	42	55	0.81	-0.095	3.773	0.013	0.01	0	44.7	40	51.2	138	126	0	34	33	33
2025	4	18	15	52	55	0.761	-0.089	3.773	0.01	0.007	0	45.2	40.4	49.9	138	127	0	33	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	18	16	2	55	0.794	-0.079	3.776	0.01	0.007	0	44.3	39.6	50.3	137	125	0	34	33	33
2025	4	18	16	12	55	0.791	-0.089	3.773	0.016	0.013	0	44.3	39.6	49.9	137	125	0	34	33	34
2025	4	18	16	22	55	0.807	-0.108	3.773	0.01	0.007	0	44.3	40	50.7	137	125	0	34	32	33
2025	4	18	16	32	55	0.853	-0.102	3.773	0.01	0.007	0	44.3	40	51.2	137	125	0	34	32	33
2025	4	18	16	42	55	0.807	-0.059	3.776	0.013	0.01	0	44.3	39.1	50.3	137	124	0	34	33	33
2025	4	18	16	52	55	0.81	-0.089	3.773	0.016	0.013	0	44.3	39.1	49.9	137	124	0	34	33	33
2025	4	18	17	2	55	0.787	-0.066	3.773	0.013	0.01	0	43.9	39.1	51.2	136	124	0	34	33	33
2025	4	18	17	12	55	0.876	-0.079	3.773	0.016	0.013	0	43.9	39.1	49.9	136	124	0	34	33	34
2025	4	18	17	22	55	0.801	-0.095	3.773	0.01	0.007	0	43.9	39.1	49.9	136	124	0	34	33	33
2025	4	18	17	32	55	0.85	-0.098	3.773	0.013	0.01	0	43.9	39.6	50.3	136	124	0	34	32	33
2025	4	18	17	42	55	0.797	-0.075	3.773	0.013	0.01	0	43.9	39.1	50.3	136	124	0	34	33	33
2025	4	18	17	52	55	0.801	-0.118	3.77	0.016	0.016	0	43.9	39.1	49.5	136	124	0	34	33	34
2025	4	18	18	2	55	0.807	-0.092	3.773	0.013	0.01	0	43.9	39.1	50.7	136	124	0	34	33	34
2025	4	18	18	12	55	0.804	-0.095	3.773	0.013	0.01	0	43.9	39.1	50.3	136	124	0	34	33	33
2025	4	18	18	22	55	0.807	-0.075	3.773	0.016	0.013	0	44.3	40	50.7	137	125	0	34	32	33
2025	4	18	18	32	55	0.817	-0.066	3.77	0.013	0.01	0	44.3	39.6	52.9	137	125	0	34	33	33
2025	4	18	18	42	55	0.817	-0.102	3.77	0.013	0.01	0	44.3	39.6	50.3	137	125	0	34	33	34
2025	4	18	18	52	55	0.784	-0.079	3.773	0.016	0.013	0	44.7	40.4	50.7	138	126	0	34	32	33
2025	4	18	19	2	55	0.794	-0.069	3.77	0.01	0.007	0	45.2	40.4	49.9	139	127	0	34	33	34
2025	4	18	19	12	55	0.827	-0.102	3.77	0.016	0.016	0	45.2	40.9	51.2	139	127	0	34	32	33
2025	4	18	19	22	55	0.781	-0.075	3.773	0.013	0.01	0	45.6	40.4	50.7	140	127	0	34	33	34
2025	4	18	19	32	55	0.827	-0.072	3.77	0.016	0.013	0	45.6	40.4	50.7	140	127	0	34	33	33
2025	4	18	19	42	55	0.81	-0.092	3.77	0.01	0.007	0	44.7	40.4	53.3	139	127	0	35	33	33
2025	4	18	19	52	55	0.794	-0.089	3.77	0.013	0.01	0	46	41.3	50.3	140	128	0	33	32	34
2025	4	18	20	2	55	0.814	-0.072	3.77	0.01	0.007	0	45.6	40.9	52.5	140	127	0	34	32	33
2025	4	18	20	12	55	0.804	-0.056	3.77	0.016	0.013	0	45.6	40.4	51.6	140	128	0	34	34	34
2025	4	18	20	22	55	0.797	-0.079	3.766	0.013	0.01	0	45.6	41.3	53.8	140	128	0	34	32	34
2025	4	18	20	32	55	0.801	-0.092	3.77	0.013	0.01	0	45.2	40.4	53.3	140	127	0	35	33	34
2025	4	18	20	42	55	0.807	-0.092	3.77	0.01	0.007	0	45.6	40	52.5	140	127	0	34	34	34
2025	4	18	20	52	55	0.817	-0.072	3.77	0.016	0.013	0	45.2	40.9	51.2	139	127	0	34	32	34
2025	4	18	21	2	55	0.791	-0.052	3.77	0.01	0.007	0	46	40	47.7	140	127	0	33	34	34
2025	4	18	21	12	55	0.817	-0.115	3.77	0.01	0.007	0	45.2	40.4	49.5	139	127	0	34	33	34
2025	4	18	21	22	55	0.784	-0.072	3.77	0.01	0.007	0	45.2	40.4	49.5	139	127	0	34	33	33
2025	4	18	21	32	55	0.827	-0.082	3.77	0.01	0.007	0	45.2	40.4	49.9	139	127	0	34	33	34
2025	4	18	21	42	55	0.774	-0.082	3.77	0.01	0.007	0	45.2	40.4	52	139	127	0	34	33	34
2025	4	18	21	52	55	0.787	-0.098	3.77	0.016	0.016	0	45.2	40	49.9	139	127	0	34	34	34
2025	4	18	22	2	55	0.807	-0.128	3.77	0.01	0.007	0	45.2	40.4	61.5	139	127	0	34	33	34
2025	4	18	22	12	55	0.794	-0.066	3.773	0.013	0.01	0	45.6	40.9	72.7	140	128	0	34	33	34
2025	4	18	22	22	55	0.817	-0.085	3.773	0.013	0.01	0	44.7	40	72.2	139	127	0	35	34	34
2025	4	18	22	32	55	0.856	-0.105	3.773	0.016	0.013	0	44.7	40	72.7	138	126	0	34	33	33
2025	4	18	22	42	55	0.843	-0.125	3.77	0.013	0.01	0	44.7	40	71.4	138	126	0	34	33	33
2025	4	18	22	52	55	0.774	-0.102	3.77	0.016	0.016	0	45.2	40.4	72.2	139	127	0	34	33	34
2025	4	18	23	2	55	0.83	-0.105	3.77	0.016	0.013	0	44.7	40	72.7	138	126	0	34	33	34
2025	4	18	23	12	55	0.853	-0.069	3.77	0.013	0.01	0	44.3	40.4	72.2	138	126	0	35	32	34
2025	4	18	23	22	55	0.814	-0.095	3.77	0.016	0.013	0	44.7	40.4	70.5	138	126	0	34	32	34
2025	4	18	23	32	55	0.797	-0.128	3.77	0.013	0.01	0	44.3	40	71.8	138	126	0	35	33	34
2025	4	18	23	42	55	0.814	-0.089	3.77	0.013	0.01	0	43.9	40	71	137	126	0	35	33	34
2025	4	18	23	52	55	0.804	-0.115	3.77	0.01	0.007	0	44.7	40	72.2	138	126	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	19	0	2	55	0.791	-0.105	3.77	0.01	0.007	0	44.7	40	72.2	138	126	0	34	33	34
2025	4	19	0	12	55	0.771	-0.092	3.77	0.013	0.01	0	44.3	39.6	73.1	137	125	0	34	33	34
2025	4	19	0	22	55	0.863	-0.108	3.77	0.01	0.007	0	44.3	40	74	137	126	0	34	33	33
2025	4	19	0	32	55	0.814	-0.075	3.77	0.01	0.007	0	44.3	40	72.7	138	126	0	35	33	34
2025	4	19	0	42	55	0.843	-0.105	3.77	0.016	0.013	0	44.7	39.6	73.1	138	125	0	34	33	34
2025	4	19	0	52	55	0.791	-0.095	3.77	0.01	0.007	0	44.3	39.6	73.1	137	126	0	34	34	34
2025	4	19	1	2	55	0.853	-0.115	3.77	0.013	0.01	0	43.4	39.6	73.5	136	125	0	35	33	34
2025	4	19	1	12	55	0.781	-0.062	3.77	0.013	0.01	0	43.9	39.6	73.5	137	125	0	35	33	34
2025	4	19	1	22	55	0.797	-0.102	3.77	0.01	0.007	0	44.3	39.6	70.5	137	125	0	34	33	34
2025	4	19	1	32	55	0.82	-0.092	3.77	0.01	0.007	0	44.3	40	58.5	137	125	0	34	32	33
2025	4	19	1	42	55	0.823	-0.095	3.77	0.016	0.016	0	43.9	39.1	73.5	137	125	0	35	34	34
2025	4	19	1	52	55	0.84	-0.095	3.77	0.01	0.007	0	43.9	39.6	73.5	137	125	0	35	33	34
2025	4	19	2	2	55	0.81	-0.085	3.77	0.013	0.01	0	44.3	39.6	73.1	137	125	0	34	33	34
2025	4	19	2	12	55	0.833	-0.098	3.77	0.016	0.013	0	43.9	39.6	73.1	136	125	0	34	33	34
2025	4	19	2	22	55	0.82	-0.098	3.77	0.013	0.01	0	44.7	39.6	73.1	137	125	0	33	33	34
2025	4	19	2	32	55	0.82	-0.082	3.77	0.013	0.01	0	43.9	39.1	72.2	137	125	0	35	34	34
2025	4	19	2	42	55	0.846	-0.069	3.77	0.01	0.007	0	43.9	39.6	73.1	136	125	0	34	33	34
2025	4	19	2	52	55	0.846	-0.075	3.77	0.01	0.007	0	43.4	39.1	72.7	136	124	0	35	33	34
2025	4	19	3	2	55	0.846	-0.108	3.77	0.01	0.007	0	43.9	39.6	74	136	125	0	34	33	33
2025	4	19	3	12	55	0.81	-0.112	3.766	0.013	0.01	0	43.9	39.1	72.7	137	125	0	35	34	34
2025	4	19	3	22	55	0.82	-0.115	3.766	0.01	0.007	0	44.3	39.6	72.7	137	125	0	34	33	34
2025	4	19	3	32	55	0.827	-0.085	3.766	0.01	0.007	0	43.9	39.6	72.7	137	125	0	35	33	34
2025	4	19	3	42	55	0.791	-0.085	3.766	0.013	0.01	0	43.9	39.6	72.2	136	125	0	34	33	34
2025	4	19	3	52	55	0.814	-0.085	3.766	0.013	0.01	0	44.3	39.6	71.8	137	125	0	34	33	34
2025	4	19	4	2	55	0.817	-0.128	3.766	0.016	0.016	0	43.9	39.1	72.2	136	124	0	34	33	34
2025	4	19	4	12	55	0.81	-0.121	3.766	0.01	0.007	0	43.9	39.1	72.2	136	125	0	34	34	33
2025	4	19	4	22	55	0.843	-0.098	3.766	0.01	0.007	0	43.9	39.1	72.2	136	124	0	34	33	33
2025	4	19	4	32	55	0.823	-0.118	3.766	0.016	0.013	0	43.9	39.6	72.2	137	125	0	35	33	34
2025	4	19	4	42	55	0.797	-0.089	3.766	0.01	0.007	0	43.9	39.6	72.2	136	125	0	34	33	34
2025	4	19	4	52	55	0.853	-0.098	3.766	0.013	0.01	0	43.9	39.1	71.4	136	124	0	34	33	34
2025	4	19	5	2	55	0.85	-0.095	3.766	0.013	0.01	0	43.9	39.6	72.2	136	124	0	34	32	34
2025	4	19	5	12	55	0.83	-0.056	3.766	0.016	0.013	0	43.9	39.1	72.2	136	124	0	34	33	34
2025	4	19	5	22	55	0.84	-0.098	3.766	0.013	0.01	0	43.4	39.1	72.7	135	124	0	34	33	34
2025	4	19	5	32	55	0.814	-0.085	3.766	0.013	0.01	0	43	38.7	71	135	123	0	35	33	34
2025	4	19	5	42	55	0.814	-0.075	3.766	0.016	0.013	0	42.6	37.8	72.7	133	122	0	34	34	34
2025	4	19	5	52	55	0.837	-0.098	3.766	0.016	0.013	0	42.6	37.8	73.1	133	122	0	34	34	34
2025	4	19	6	2	55	0.814	-0.098	3.766	0.013	0.01	0	42.1	37.4	73.5	132	121	0	34	34	34
2025	4	19	6	12	55	0.85	-0.098	3.766	0.013	0.01	0	41.7	37.4	73.5	131	120	0	34	33	34
2025	4	19	6	22	55	0.801	-0.085	3.766	0.016	0.013	0	41.3	37	73.5	131	119	0	35	33	34
2025	4	19	6	32	55	0.81	-0.095	3.766	0.01	0.007	0	41.7	37.8	73.5	132	121	0	35	33	34
2025	4	19	6	42	55	0.764	-0.108	3.766	0.01	0.007	0	41.7	37	74.4	131	120	0	34	34	33
2025	4	19	6	52	55	0.853	-0.121	3.77	0.016	0.013	0	41.3	37	74.4	130	119	0	34	33	34
2025	4	19	7	2	55	0.843	-0.112	3.766	0.016	0.013	0	40.9	36.1	74.4	129	118	0	34	34	34
2025	4	19	7	12	55	0.81	-0.095	3.77	0.013	0.01	0	40.9	37.4	74	130	120	0	35	33	34
2025	4	19	7	22	55	0.817	-0.085	3.77	0.016	0.013	0	41.3	37	74.8	130	119	0	34	33	33
2025	4	19	7	32	55	0.846	-0.049	3.77	0.013	0.01	0	40.4	36.1	74	129	118	0	35	34	35
2025	4	19	7	42	55	0.807	-0.052	3.77	0.013	0.01	0	41.3	37	74	130	119	0	34	33	34
2025	4	19	7	52	55	0.814	-0.089	3.77	0.013	0.01	0	41.7	37.8	73.1	132	121	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	19	8	2	55	0.827	-0.092	3.77	0.01	0.007	0	41.7	37	73.5	131	120	0	34	34	34
2025	4	19	8	12	55	0.794	-0.098	3.77	0.01	0.007	0	41.7	37.4	73.5	131	120	0	34	33	34
2025	4	19	8	22	55	0.823	-0.072	3.77	0.01	0.007	0	41.7	37.8	74	132	121	0	35	33	34
2025	4	19	8	32	55	0.833	-0.115	3.77	0.01	0.007	0	41.3	37.4	74	131	120	0	35	33	34
2025	4	19	8	42	55	0.833	-0.085	3.77	0.013	0.01	0	41.3	37.4	74	130	120	0	34	33	34
2025	4	19	8	52	55	0.81	-0.066	3.77	0.013	0.01	0	41.7	37.8	74	132	121	0	35	33	34
2025	4	19	9	2	55	0.801	-0.072	3.77	0.013	0.01	0	41.7	37.8	74	131	120	0	34	32	34
2025	4	19	9	12	55	0.863	-0.108	3.773	0.01	0.007	0	41.3	37.4	73.5	130	120	0	34	33	34
2025	4	19	9	22	55	0.778	-0.102	3.77	0.013	0.01	0	41.7	37.8	73.1	131	121	0	34	33	34
2025	4	19	9	32	55	0.85	-0.095	3.773	0.016	0.013	0	41.3	38.3	74	131	121	0	35	32	34
2025	4	19	9	42	55	0.817	-0.115	3.773	0.013	0.01	0	41.3	37.8	73.5	131	121	0	35	33	34
2025	4	19	9	52	55	0.837	-0.108	3.773	0.01	0.007	0	41.7	37.8	73.5	132	121	0	35	33	34
2025	4	19	10	2	55	0.853	-0.098	3.773	0.013	0.01	0	42.1	37.4	74	132	120	0	34	33	33
2025	4	19	10	12	55	0.833	-0.108	3.773	0.013	0.01	0	41.7	37	73.5	131	120	0	34	34	34
2025	4	19	10	22	55	0.81	-0.131	3.773	0.013	0.01	0	41.7	37.4	71	131	120	0	34	33	34
2025	4	19	10	32	55	0.833	-0.092	3.773	0.01	0.007	0	42.1	37.8	73.1	132	121	0	34	33	34
2025	4	19	10	42	55	0.863	-0.141	3.773	0.01	0.007	0	41.7	37	71.8	131	119	0	34	33	34
2025	4	19	10	52	55	0.804	-0.125	3.773	0.013	0.01	0	41.7	37	73.5	131	119	0	34	33	33
2025	4	19	11	2	55	0.804	-0.115	3.773	0.016	0.013	0	41.7	37.4	72.7	132	120	0	35	33	34
2025	4	19	11	12	55	0.81	-0.059	3.773	0.013	0.01	0	42.1	38.3	56.8	132	121	0	34	32	34
2025	4	19	11	22	55	0.82	-0.128	3.773	0.01	0.007	0	41.3	37.4	58.5	131	120	0	35	33	34
2025	4	19	11	32	55	0.801	-0.108	3.776	0.016	0.013	0	41.7	37.8	73.5	131	120	0	34	32	33
2025	4	19	11	42	55	0.82	-0.102	3.776	0.013	0.01	0	41.7	37.8	71.8	131	120	0	34	32	34
2025	4	19	11	52	55	0.83	-0.128	3.776	0.01	0.007	0	41.7	37	73.1	131	119	0	34	33	34
2025	4	19	12	2	55	0.807	-0.075	3.776	0.01	0.007	0	42.1	37.4	72.7	132	120	0	34	33	33
2025	4	19	12	12	55	0.807	-0.115	3.776	0.013	0.01	0	41.7	36.5	70.5	131	119	0	34	34	34
2025	4	19	12	22	55	0.807	-0.118	3.776	0.01	0.007	0	41.7	37.4	71.8	131	119	0	34	32	34
2025	4	19	12	32	55	0.823	-0.075	3.776	0.01	0.007	0	41.7	37.4	72.2	131	120	0	34	33	34
2025	4	19	12	42	55	0.814	-0.089	3.776	0.016	0.013	0	41.7	37.8	72.7	131	120	0	34	32	34
2025	4	19	12	52	55	0.833	-0.108	3.776	0.01	0.007	0	41.7	37.4	67.5	131	120	0	34	33	33
2025	4	19	13	2	55	0.827	-0.072	3.773	0.013	0.01	0	42.1	37.8	51.6	132	120	0	34	32	33
2025	4	19	13	12	55	0.801	-0.092	3.77	0.01	0.007	0	41.7	38.3	52.9	131	121	0	34	32	33
2025	4	19	13	22	55	0.833	-0.115	3.77	0.016	0.016	0	41.7	37.4	49.5	131	120	0	34	33	34
2025	4	19	13	32	55	0.823	-0.072	3.773	0.01	0.007	0	42.1	37.8	52	132	121	0	34	33	33
2025	4	19	13	42	55	0.83	-0.062	3.773	0.01	0.007	0	42.1	37.8	49.9	132	121	0	34	33	34
2025	4	19	13	52	55	0.817	-0.066	3.773	0.01	0.007	0	42.1	37.4	50.7	132	121	0	34	34	33
2025	4	19	14	2	55	0.81	-0.105	3.773	0.01	0.007	0	41.7	37.4	53.3	131	120	0	34	33	33
2025	4	19	14	12	55	0.794	-0.102	3.773	0.01	0.007	0	42.1	38.3	49.9	132	121	0	34	32	32
2025	4	19	14	22	55	0.81	-0.085	3.773	0.01	0.007	0	41.7	37.8	58.5	131	120	0	34	32	34
2025	4	19	14	32	55	0.83	-0.098	3.77	0.016	0.016	0	42.1	38.3	52	132	121	0	34	32	33
2025	4	19	14	42	55	0.787	-0.095	3.773	0.01	0.007	0	42.1	37.8	52	132	121	0	34	33	33
2025	4	19	14	52	55	0.801	-0.092	3.773	0.013	0.01	0	42.1	37.8	49.5	132	121	0	34	33	33
2025	4	19	15	2	55	0.814	-0.092	3.773	0.013	0.01	0	41.7	37.8	47.3	131	121	0	34	33	34
2025	4	19	15	12	55	0.83	-0.062	3.773	0.013	0.01	0	42.1	38.3	50.7	132	121	0	34	32	33
2025	4	19	15	22	55	0.781	-0.072	3.773	0.013	0.01	0	42.1	37.8	48.6	132	121	0	34	33	34
2025	4	19	15	32	55	0.797	-0.059	3.773	0.013	0.01	0	42.1	37.8	48.6	132	121	0	34	33	33
2025	4	19	15	42	55	0.814	-0.089	3.773	0.01	0.007	0	41.7	38.3	48.2	132	121	0	35	32	33
2025	4	19	15	52	55	0.794	-0.112	3.773	0.01	0.007	0	42.1	37.8	52.5	132	121	0	34	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	19	16	2	55	0.807	-0.092	3.773	0.01	0.007	0	42.1	37.4	49.9	131	120	0	33	33	34
2025	4	19	16	12	55	0.814	-0.115	3.773	0.013	0.01	0	41.7	37.4	49	131	120	0	34	33	33
2025	4	19	16	22	55	0.814	-0.059	3.773	0.016	0.013	0	42.1	37.4	48.6	132	120	0	34	33	34
2025	4	19	16	32	55	0.794	-0.112	3.773	0.016	0.013	0	41.7	37.4	46	131	120	0	34	33	34
2025	4	19	16	42	55	0.817	-0.075	3.773	0.013	0.01	0	41.7	37.4	49.5	131	120	0	34	33	33
2025	4	19	16	52	55	0.827	-0.069	3.773	0.01	0.007	0	42.1	37.4	52.9	132	120	0	34	33	34
2025	4	19	17	2	55	0.791	-0.082	3.776	0.013	0.01	0	42.1	37.8	47.3	132	120	0	34	32	33
2025	4	19	17	12	55	0.827	-0.089	3.773	0.013	0.01	0	41.7	37.8	49.5	131	120	0	34	32	34
2025	4	19	17	22	55	0.81	-0.105	3.776	0.016	0.013	0	42.1	37.8	49.9	132	121	0	34	33	34
2025	4	19	17	32	55	0.84	-0.079	3.78	0.013	0.01	0	42.6	37.8	65.4	133	121	0	34	33	33
2025	4	19	17	42	55	0.827	-0.059	3.776	0.013	0.01	0	42.1	38.3	47.7	132	121	0	34	32	34
2025	4	19	17	52	55	0.797	-0.128	3.776	0.01	0.007	0	42.1	37.8	47.7	132	121	0	34	33	34
2025	4	19	18	2	55	0.82	-0.112	3.78	0.013	0.01	0	42.6	37.8	62.8	133	121	0	34	33	33
2025	4	19	18	12	55	0.843	-0.108	3.78	0.01	0.007	0	42.6	38.3	58	133	122	0	34	33	33
2025	4	19	18	22	55	0.781	-0.052	3.78	0.01	0.007	0	42.6	38.3	69.7	133	122	0	34	33	34
2025	4	19	18	32	55	0.823	-0.102	3.78	0.01	0.007	0	43	37.8	74	134	122	0	34	34	34
2025	4	19	18	42	55	0.833	-0.075	3.78	0.016	0.013	0	43	38.7	58	134	123	0	34	33	34
2025	4	19	18	52	55	0.801	-0.075	3.776	0.016	0.013	0	43	38.7	48.6	134	123	0	34	33	33
2025	4	19	19	2	55	0.84	-0.085	3.776	0.01	0.007	0	43.9	39.1	53.8	136	124	0	34	33	34
2025	4	19	19	12	55	0.833	-0.098	3.776	0.01	0.007	0	43.4	39.6	48.6	136	125	0	35	33	34
2025	4	19	19	22	55	0.807	-0.072	3.776	0.01	0.007	0	44.3	39.6	50.7	137	125	0	34	33	33
2025	4	19	19	32	55	0.823	-0.072	3.78	0.016	0.013	0	43.9	40	52	137	126	0	35	33	33
2025	4	19	19	42	55	0.814	-0.085	3.78	0.013	0.01	0	43.9	39.1	72.7	137	125	0	35	34	33
2025	4	19	19	52	55	0.83	-0.128	3.78	0.016	0.013	0	44.3	39.6	74.4	137	125	0	34	33	34
2025	4	19	20	2	55	0.801	-0.131	3.78	0.01	0.007	0	44.3	39.6	74.4	137	125	0	34	33	33
2025	4	19	20	12	55	0.804	-0.112	3.78	0.016	0.013	0	44.3	39.6	74.4	137	125	0	34	33	34
2025	4	19	20	22	55	0.853	-0.102	3.78	0.01	0.007	0	44.3	40	74.4	137	126	0	34	33	33
2025	4	19	20	32	55	0.846	-0.102	3.78	0.016	0.013	0	43.9	40	74.4	136	126	0	34	33	34
2025	4	19	20	42	55	0.83	-0.043	3.78	0.013	0.01	0	44.3	40	74	137	126	0	34	33	34
2025	4	19	20	52	55	0.83	-0.112	3.78	0.01	0.007	0	44.3	40.4	74	137	126	0	34	32	33
2025	4	19	21	2	55	0.833	-0.095	3.78	0.013	0.01	0	43.4	39.6	74.4	136	125	0	35	33	33
2025	4	19	21	12	55	0.83	-0.075	3.78	0.013	0.01	0	44.3	39.6	73.5	137	126	0	34	34	34
2025	4	19	21	22	55	0.843	-0.082	3.78	0.016	0.013	0	44.3	39.6	72.7	137	126	0	34	34	33
2025	4	19	21	32	55	0.827	-0.102	3.78	0.013	0.01	0	44.7	39.6	69.2	139	126	0	35	34	34
2025	4	19	21	42	55	0.83	-0.085	3.776	0.013	0.01	0	45.2	39.6	73.5	139	125	0	34	33	34
2025	4	19	21	52	55	0.863	-0.118	3.776	0.013	0.01	0	45.2	39.6	74	139	125	0	34	33	34
2025	4	19	22	2	55	0.827	-0.095	3.776	0.016	0.013	0	45.6	40	72.7	140	126	0	34	33	34
2025	4	19	22	12	55	0.873	-0.118	3.776	0.01	0.007	0	45.2	39.6	74	139	125	0	34	33	34
2025	4	19	22	22	55	0.794	-0.082	3.776	0.016	0.013	0	45.2	39.6	73.5	139	125	0	34	33	34
2025	4	19	22	32	55	0.84	-0.108	3.776	0.01	0.007	0	45.2	39.6	73.5	139	125	0	34	33	34
2025	4	19	22	42	55	0.863	-0.112	3.776	0.013	0.01	0	44.7	39.6	74	139	125	0	35	33	34
2025	4	19	22	52	55	0.804	-0.072	3.776	0.013	0.01	0	44.7	39.6	73.1	139	126	0	35	34	34
2025	4	19	23	2	55	0.902	-0.062	3.776	0.013	0.01	0	44.7	39.6	74	138	125	0	34	33	34
2025	4	19	23	12	55	0.837	-0.082	3.776	0.013	0.01	0	44.7	39.6	74	139	125	0	35	33	34
2025	4	19	23	22	55	0.833	-0.105	3.776	0.01	0.007	0	45.2	39.6	73.1	139	125	0	34	33	34
2025	4	19	23	32	55	0.817	-0.105	3.776	0.01	0.007	0	45.2	40	73.5	139	126	0	34	33	34
2025	4	19	23	42	55	0.794	-0.098	3.776	0.01	0.007	0	45.6	40	73.5	140	126	0	34	33	34
2025	4	19	23	52	55	0.801	-0.098	3.776	0.016	0.013	0	45.6	40	73.1	140	126	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	20	0	2	55	0.823	-0.098	3.776	0.016	0.013	0	44.7	40	72.7	139	126	0	35	33	34
2025	4	20	0	12	55	0.837	-0.095	3.776	0.013	0.01	0	44.7	40	74	139	126	0	35	33	33
2025	4	20	0	22	55	0.823	-0.056	3.776	0.01	0.007	0	45.2	40	73.1	139	126	0	34	33	35
2025	4	20	0	32	55	0.81	-0.056	3.776	0.013	0.01	0	45.2	39.6	73.1	139	125	0	34	33	34
2025	4	20	0	42	55	0.804	-0.115	3.776	0.016	0.013	0	44.7	39.6	72.7	139	125	0	35	33	34
2025	4	20	0	52	55	0.81	-0.089	3.776	0.013	0.01	0	45.2	40	73.5	139	126	0	34	33	34
2025	4	20	1	2	55	0.801	-0.085	3.776	0.013	0.01	0	45.2	39.6	73.1	139	126	0	34	34	34
2025	4	20	1	12	55	0.837	-0.112	3.776	0.01	0.007	0	44.3	39.6	73.1	138	125	0	35	33	34
2025	4	20	1	22	55	0.869	-0.072	3.776	0.01	0.007	0	44.7	39.6	73.5	138	125	0	34	33	34
2025	4	20	1	32	55	0.837	-0.098	3.776	0.01	0.007	0	45.2	39.6	73.5	139	125	0	34	33	33
2025	4	20	1	42	55	0.823	-0.105	3.776	0.01	0.007	0	44.7	39.6	73.1	138	125	0	34	33	34
2025	4	20	1	52	55	0.85	-0.105	3.776	0.01	0.007	0	45.2	39.6	72.2	139	125	0	34	33	34
2025	4	20	2	2	55	0.794	-0.085	3.776	0.013	0.01	0	45.2	40	71.8	139	126	0	34	33	35
2025	4	20	2	12	55	0.781	-0.108	3.776	0.01	0.007	0	44.3	39.1	73.5	138	125	0	35	34	33
2025	4	20	2	22	55	0.827	-0.098	3.776	0.013	0.01	0	44.7	39.1	72.7	138	125	0	34	34	34
2025	4	20	2	32	55	0.827	-0.098	3.776	0.01	0.007	0	44.3	39.6	73.5	138	125	0	35	33	34
2025	4	20	2	42	55	0.873	-0.112	3.776	0.016	0.013	0	44.3	39.6	73.5	138	125	0	35	33	34
2025	4	20	2	52	55	0.83	-0.098	3.776	0.016	0.013	0	44.7	40	73.1	138	126	0	34	33	34
2025	4	20	3	2	55	0.823	-0.098	3.776	0.01	0.007	0	44.7	39.6	73.5	138	125	0	34	33	34
2025	4	20	3	12	55	0.804	-0.075	3.776	0.016	0.013	0	44.3	40	73.1	138	126	0	35	33	34
2025	4	20	3	22	55	0.82	-0.115	3.776	0.01	0.007	0	44.3	39.6	72.7	137	125	0	34	33	34
2025	4	20	3	32	55	0.837	-0.118	3.776	0.01	0.007	0	44.3	39.6	73.1	138	125	0	35	33	34
2025	4	20	3	42	55	0.823	-0.079	3.78	0.016	0.016	0	44.3	39.1	73.1	137	125	0	34	34	34
2025	4	20	3	52	55	0.856	-0.075	3.78	0.01	0.007	0	44.3	39.1	73.1	137	125	0	34	34	34
2025	4	20	4	2	55	0.837	-0.072	3.78	0.016	0.016	0	44.7	40	73.1	138	125	0	34	32	34
2025	4	20	4	12	55	0.866	-0.085	3.78	0.01	0.007	0	44.3	39.6	73.1	137	125	0	34	33	34
2025	4	20	4	22	55	0.837	-0.115	3.78	0.01	0.007	0	44.3	40	73.5	137	125	0	34	32	33
2025	4	20	4	32	55	0.833	-0.085	3.78	0.01	0.007	0	44.3	39.6	73.1	137	125	0	34	33	34
2025	4	20	4	42	55	0.856	-0.118	3.78	0.013	0.01	0	43.9	39.1	72.7	137	124	0	35	33	34
2025	4	20	4	52	55	0.85	-0.082	3.78	0.016	0.013	0	44.3	39.6	73.1	137	125	0	34	33	34
2025	4	20	5	2	55	0.804	-0.085	3.78	0.01	0.007	0	43.9	39.6	72.2	137	125	0	35	33	34
2025	4	20	5	12	55	0.889	-0.102	3.78	0.013	0.01	0	44.3	39.1	73.5	137	124	0	34	33	34
2025	4	20	5	22	55	0.823	-0.056	3.78	0.01	0.007	0	43.9	39.1	73.1	136	124	0	34	33	34
2025	4	20	5	32	55	0.82	-0.059	3.78	0.013	0.01	0	43.4	38.7	73.5	136	124	0	35	34	34
2025	4	20	5	42	55	0.81	-0.085	3.78	0.013	0.01	0	43.4	37.8	74	135	122	0	34	34	33
2025	4	20	5	52	55	0.81	-0.072	3.78	0.01	0.007	0	43	38.7	73.5	135	123	0	35	33	34
2025	4	20	6	2	55	0.81	-0.098	3.78	0.01	0.007	0	43	38.3	74	134	123	0	34	34	34
2025	4	20	6	12	55	0.86	-0.098	3.78	0.013	0.01	0	42.6	38.3	74	134	122	0	35	33	34
2025	4	20	6	22	55	0.817	-0.115	3.78	0.016	0.013	0	41.7	37.8	74	132	121	0	35	33	34
2025	4	20	6	32	55	0.797	-0.102	3.78	0.013	0.01	0	42.6	37.4	74	133	121	0	34	34	34
2025	4	20	6	42	55	0.863	-0.082	3.78	0.013	0.01	0	41.7	37	75.3	131	120	0	34	34	33
2025	4	20	6	52	55	0.83	-0.092	3.78	0.01	0.007	0	41.3	37	74.8	131	120	0	35	34	34
2025	4	20	7	2	55	0.807	-0.052	3.78	0.016	0.013	0	42.1	37.8	74	133	121	0	35	33	34
2025	4	20	7	12	55	0.82	-0.115	3.78	0.01	0.007	0	42.1	37.4	74.4	132	120	0	34	33	34
2025	4	20	7	22	55	0.83	-0.075	3.78	0.01	0.007	0	41.7	37.4	74	131	120	0	34	33	35
2025	4	20	7	32	55	0.82	-0.098	3.78	0.016	0.013	0	42.6	38.3	74.4	133	122	0	34	33	34
2025	4	20	7	42	55	0.801	-0.095	3.78	0.01	0.007	0	42.1	38.3	74.8	132	122	0	34	33	34
2025	4	20	7	52	55	0.83	-0.102	3.78	0.01	0.007	0	42.1	37.8	74.8	132	121	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	20	8	2	55	0.83	-0.098	3.783	0.016	0.013	0	42.1	38.3	74.8	132	122	0	34	33	34
2025	4	20	8	12	55	0.797	-0.085	3.783	0.013	0.01	0	42.6	37.8	74.4	133	122	0	34	34	34
2025	4	20	8	22	55	0.807	-0.079	3.783	0.01	0.007	0	42.1	38.3	73.5	132	121	0	34	32	34
2025	4	20	8	32	55	0.804	-0.075	3.783	0.01	0.007	0	42.6	38.3	72.7	133	122	0	34	33	34
2025	4	20	8	42	55	0.804	-0.102	3.783	0.013	0.01	0	43	38.7	72.7	134	123	0	34	33	34
2025	4	20	8	52	55	0.827	-0.092	3.783	0.013	0.01	0	43	38.7	74.8	134	123	0	34	33	34
2025	4	20	9	2	55	0.869	-0.098	3.783	0.01	0.007	0	42.1	38.3	75.3	132	122	0	34	33	34
2025	4	20	9	12	55	0.814	-0.079	3.783	0.013	0.01	0	43	38.3	74.8	134	123	0	34	34	34
2025	4	20	9	22	55	0.827	-0.082	3.783	0.01	0.007	0	42.1	38.3	75.3	132	122	0	34	33	34
2025	4	20	9	32	55	0.85	-0.079	3.783	0.01	0.007	0	42.1	37.8	75.7	132	121	0	34	33	34
2025	4	20	9	42	55	0.84	-0.052	3.783	0.01	0.007	0	42.1	38.3	75.7	132	121	0	34	32	34
2025	4	20	9	52	55	0.823	-0.102	3.783	0.013	0.01	0	42.6	38.3	75.3	133	122	0	34	33	34
2025	4	20	10	2	55	0.85	-0.095	3.783	0.01	0.007	0	41.7	37.4	76.1	132	120	0	35	33	33
2025	4	20	10	12	55	0.827	-0.092	3.786	0.013	0.01	0	42.6	38.3	71.4	133	122	0	34	33	34
2025	4	20	10	22	55	0.827	-0.125	3.786	0.01	0.007	0	42.1	37.8	73.1	132	121	0	34	33	34
2025	4	20	10	32	55	0.817	-0.089	3.786	0.01	0.007	0	42.6	38.7	73.1	133	122	0	34	32	33
2025	4	20	10	42	55	0.83	-0.102	3.786	0.013	0.01	0	42.1	37.8	75.7	132	121	0	34	33	34
2025	4	20	10	52	55	0.869	-0.115	3.786	0.013	0.01	0	42.1	38.3	74.4	132	122	0	34	33	33
2025	4	20	11	2	55	0.84	-0.105	3.786	0.016	0.016	0	41.7	37.4	69.7	132	121	0	35	34	34
2025	4	20	11	12	55	0.797	-0.128	3.786	0.01	0.007	0	42.6	37.8	50.7	132	121	0	33	33	33
2025	4	20	11	22	55	0.827	-0.121	3.786	0.016	0.016	0	42.6	38.3	51.2	133	122	0	34	33	34
2025	4	20	11	32	55	0.82	-0.069	3.786	0.013	0.01	0	42.1	38.3	53.3	132	121	0	34	32	33
2025	4	20	11	42	55	0.787	-0.112	3.786	0.013	0.01	0	41.7	37.8	53.8	131	121	0	34	33	34
2025	4	20	11	52	55	0.804	-0.102	3.786	0.016	0.013	0	42.1	37.8	59.8	132	121	0	34	33	33
2025	4	20	12	2	55	0.84	-0.118	3.786	0.013	0.01	0	42.1	37.8	50.7	132	121	0	34	33	34
2025	4	20	12	12	55	0.833	-0.085	3.789	0.016	0.013	0	42.6	39.1	49.5	133	123	0	34	32	33
2025	4	20	12	22	55	0.807	-0.092	3.783	0.01	0.007	0	42.1	38.7	48.6	133	123	0	35	33	33
2025	4	20	12	32	55	0.853	-0.085	3.783	0.01	0.007	0	42.6	38.3	49.5	133	122	0	34	33	32
2025	4	20	12	42	55	0.837	-0.089	3.783	0.013	0.01	0	43	39.1	48.2	133	123	0	33	32	33
2025	4	20	12	52	55	0.81	-0.079	3.783	0.01	0.007	0	42.6	38.3	46	133	122	0	34	33	34
2025	4	20	13	2	55	0.801	-0.085	3.786	0.01	0.007	0	42.1	38.7	47.3	132	122	0	34	32	34
2025	4	20	13	12	55	0.804	-0.075	3.783	0.01	0.007	0	42.6	38.3	49	133	122	0	34	33	33
2025	4	20	13	22	55	0.794	-0.062	3.783	0.01	0.007	0	42.6	38.7	45.6	133	123	0	34	33	33
2025	4	20	13	32	55	0.823	-0.098	3.78	0.013	0.01	0	42.6	38.7	44.3	133	122	0	34	32	34
2025	4	20	13	42	55	0.863	-0.112	3.78	0.013	0.01	0	42.6	38.7	44.7	133	123	0	34	33	33
2025	4	20	13	52	55	0.833	-0.079	3.783	0.016	0.013	0	43	38.7	46	134	123	0	34	33	33
2025	4	20	14	2	55	0.82	-0.112	3.78	0.01	0.007	0	43	39.1	49	134	123	0	34	32	33
2025	4	20	14	12	55	0.804	-0.075	3.783	0.016	0.016	0	43.4	39.6	48.6	135	125	0	34	33	33
2025	4	20	14	22	55	0.856	-0.085	3.783	0.013	0.01	0	43.4	38.7	46	134	124	0	33	34	34
2025	4	20	14	32	55	0.85	-0.072	3.783	0.01	0.007	0	43	39.6	48.2	134	124	0	34	32	33
2025	4	20	14	42	55	0.807	-0.115	3.783	0.01	0.007	0	43	39.1	47.3	134	124	0	34	33	34
2025	4	20	14	52	55	0.833	-0.085	3.783	0.016	0.013	0	43	39.1	46.9	134	124	0	34	33	34
2025	4	20	15	2	55	0.833	-0.098	3.786	0.01	0.007	0	43	39.6	49	134	124	0	34	32	33
2025	4	20	15	12	55	0.823	-0.135	3.78	0.016	0.013	0	43	39.1	47.3	134	124	0	34	33	34
2025	4	20	15	22	55	0.807	-0.082	3.783	0.01	0.007	0	43.4	39.1	46.9	135	124	0	34	33	34
2025	4	20	15	32	55	0.837	-0.089	3.783	0.013	0.01	0	43.4	39.6	47.7	135	124	0	34	32	33
2025	4	20	15	42	55	0.791	-0.046	3.783	0.01	0.007	0	42.6	39.1	47.3	134	124	0	35	33	33
2025	4	20	15	52	55	0.833	-0.108	3.776	0.013	0.01	0	43	39.1	47.3	134	124	0	34	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	20	16	2	55	0.81	-0.079	3.776	0.013	0.01	0	43	39.6	47.3	134	124	0	34	32	34
2025	4	20	16	12	55	0.83	-0.082	3.776	0.01	0.007	0	43.4	39.1	46	135	124	0	34	33	33
2025	4	20	16	22	55	0.817	-0.102	3.776	0.013	0.01	0	43	39.1	45.6	133	123	0	33	32	33
2025	4	20	16	32	55	0.82	-0.098	3.783	0.01	0.007	0	43	39.1	47.3	134	123	0	34	32	34
2025	4	20	16	42	55	0.814	-0.072	3.78	0.013	0.01	0	43	39.1	47.7	134	124	0	34	33	34
2025	4	20	16	52	55	0.797	-0.098	3.78	0.013	0.01	0	43.4	38.7	45.2	134	123	0	33	33	34
2025	4	20	17	2	55	0.83	-0.092	3.78	0.01	0.007	0	42.6	38.7	47.7	133	122	0	34	32	33
2025	4	20	17	12	55	0.83	-0.118	3.78	0.013	0.01	0	42.6	38.7	47.7	133	123	0	34	33	33
2025	4	20	17	22	55	0.837	-0.089	3.78	0.01	0.007	0	42.6	38.3	47.3	133	122	0	34	33	34
2025	4	20	17	32	55	0.817	-0.108	3.776	0.013	0.01	0	43	38.7	46.9	133	122	0	33	32	33
2025	4	20	17	42	55	0.82	-0.102	3.783	0.013	0.01	0	42.6	38.7	65.4	133	122	0	34	32	33
2025	4	20	17	52	55	0.827	-0.121	3.78	0.013	0.01	0	43	39.1	57.6	133	123	0	33	32	33
2025	4	20	18	2	55	0.81	-0.112	3.78	0.013	0.01	0	43	39.1	59.8	134	123	0	34	32	33
2025	4	20	18	12	55	0.817	-0.095	3.78	0.01	0.007	0	43	39.6	52	134	124	0	34	32	33
2025	4	20	18	22	55	0.797	-0.144	3.783	0.013	0.01	0	43	38.7	72.2	134	123	0	34	33	34
2025	4	20	18	32	55	0.83	-0.089	3.783	0.01	0.007	0	43.4	39.1	71.8	135	124	0	34	33	34
2025	4	20	18	42	55	0.817	-0.092	3.78	0.01	0.007	0	43.4	40	55.5	135	125	0	34	32	34
2025	4	20	18	52	55	0.83	-0.112	3.783	0.013	0.01	0	43.9	40	71.4	136	125	0	34	32	33
2025	4	20	19	2	55	0.833	-0.085	3.783	0.013	0.01	0	44.3	40	67.9	137	126	0	34	33	34
2025	4	20	19	12	55	0.84	-0.085	3.78	0.01	0.007	0	44.3	40	48.6	137	126	0	34	33	33
2025	4	20	19	22	55	0.81	-0.095	3.78	0.013	0.01	0	45.2	40.9	49.9	138	127	0	33	32	34
2025	4	20	19	32	55	0.837	-0.089	3.78	0.01	0.007	0	45.6	40.4	51.2	140	127	0	34	33	34
2025	4	20	19	42	55	0.85	-0.082	3.78	0.013	0.01	0	46.4	40.4	60.6	141	127	0	33	33	34
2025	4	20	19	52	55	0.817	-0.098	3.78	0.01	0.007	0	46.4	40.4	50.3	142	127	0	34	33	33
2025	4	20	20	2	55	0.817	-0.089	3.78	0.01	0.007	0	46.4	40.9	58.9	142	127	0	34	32	33
2025	4	20	20	12	55	0.823	-0.089	3.78	0.016	0.016	0	46	40.4	55	141	127	0	34	33	33
2025	4	20	20	22	55	0.807	-0.121	3.776	0.01	0.007	0	45.6	40.4	47.3	141	127	0	35	33	33
2025	4	20	20	32	55	0.833	-0.082	3.776	0.016	0.013	0	46	40.9	49	140	127	0	33	32	34
2025	4	20	20	42	55	0.807	-0.085	3.776	0.016	0.013	0	47.7	40.4	50.7	144	126	0	33	32	33
2025	4	20	20	52	55	0.823	-0.079	3.776	0.016	0.013	0	46.9	40	48.2	143	126	0	34	33	34
2025	4	20	21	2	55	0.833	-0.085	3.776	0.01	0.007	0	46.9	40.4	53.8	143	126	0	34	32	33
2025	4	20	21	12	55	0.83	-0.115	3.78	0.01	0.007	0	46	39.6	64.9	142	125	0	35	33	34
2025	4	20	21	22	55	0.791	-0.098	3.78	0.01	0.007	0	46	40	72.2	142	126	0	35	33	34
2025	4	20	21	32	55	0.863	-0.115	3.78	0.013	0.01	0	46.4	39.6	72.7	142	125	0	34	33	33
2025	4	20	21	42	55	0.876	-0.125	3.78	0.013	0.01	0	46	39.6	74	141	125	0	34	33	34
2025	4	20	21	52	55	0.853	-0.075	3.78	0.01	0.007	0	46	40	74.8	142	126	0	35	33	34
2025	4	20	22	2	55	0.866	-0.102	3.78	0.013	0.01	0	46	40	75.3	141	125	0	34	32	33
2025	4	20	22	12	55	0.833	-0.066	3.78	0.01	0.007	0	46	39.6	75.7	141	125	0	34	33	33
2025	4	20	22	22	55	0.827	-0.092	3.78	0.013	0.01	0	46	39.6	73.5	141	125	0	34	33	34
2025	4	20	22	32	55	0.833	-0.102	3.78	0.016	0.013	0	45.2	40	74.8	140	125	0	35	32	33
2025	4	20	22	42	55	0.823	-0.089	3.776	0.013	0.01	0	45.6	39.6	73.5	140	125	0	34	33	34
2025	4	20	22	52	55	0.84	-0.105	3.78	0.016	0.016	0	45.2	40	73.5	140	125	0	35	32	35
2025	4	20	23	2	55	0.823	-0.105	3.776	0.013	0.01	0	45.2	40	74.4	140	125	0	35	32	34
2025	4	20	23	12	55	0.801	-0.075	3.78	0.013	0.01	0	45.6	39.6	74.4	140	125	0	34	33	34
2025	4	20	23	22	55	0.892	-0.095	3.776	0.01	0.007	0	45.6	39.6	74.8	140	125	0	34	33	33
2025	4	20	23	32	55	0.869	-0.069	3.776	0.013	0.01	0	46	39.6	74.4	141	125	0	34	33	34
2025	4	20	23	42	55	0.863	-0.108	3.776	0.01	0.007	0	46	39.6	73.5	141	125	0	34	33	34
2025	4	20	23	52	55	0.82	-0.085	3.776	0.01	0.007	0	46.4	40	74.4	142	126	0	34	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	21	0	2	55	0.84	-0.102	3.776	0.013	0.01	0	46.4	39.6	74.4	142	125	0	34	33	34
2025	4	21	0	12	55	0.85	-0.079	3.776	0.016	0.013	0	46.4	39.6	74.8	142	125	0	34	33	33
2025	4	21	0	22	55	0.82	-0.066	3.776	0.013	0.01	0	46.4	39.6	74	142	125	0	34	33	34
2025	4	21	0	32	55	0.807	-0.069	3.776	0.01	0.007	0	46	39.6	74.4	142	125	0	35	33	33
2025	4	21	0	42	55	0.84	-0.085	3.776	0.013	0.01	0	46	39.6	73.5	141	125	0	34	33	34
2025	4	21	0	52	55	0.833	-0.115	3.776	0.016	0.013	0	45.6	39.6	74.4	141	125	0	35	33	34
2025	4	21	1	2	55	0.83	-0.102	3.776	0.01	0.007	0	46	39.6	73.5	141	125	0	34	33	34
2025	4	21	1	12	55	0.83	-0.095	3.776	0.01	0.007	0	46	39.1	74	141	125	0	34	34	34
2025	4	21	1	22	55	0.863	-0.098	3.776	0.01	0.007	0	46	39.6	74.4	141	125	0	34	33	33
2025	4	21	1	32	55	0.856	-0.098	3.776	0.016	0.016	0	46	39.6	74.4	141	125	0	34	33	34
2025	4	21	1	42	55	0.86	-0.085	3.776	0.016	0.013	0	46	39.6	73.1	141	125	0	34	33	35
2025	4	21	1	52	55	0.833	-0.079	3.776	0.013	0.01	0	46	38.3	74	141	123	0	34	34	34
2025	4	21	2	2	55	0.843	-0.115	3.776	0.01	0.007	0	46	39.1	73.5	141	124	0	34	33	34
2025	4	21	2	12	55	0.873	-0.125	3.776	0.01	0.007	0	45.6	39.1	74.8	140	124	0	34	33	33
2025	4	21	2	22	55	0.876	-0.062	3.776	0.01	0.007	0	46.4	38.7	74.4	142	124	0	34	34	34
2025	4	21	2	32	55	0.85	-0.085	3.776	0.013	0.01	0	46.9	39.6	74	143	125	0	34	33	34
2025	4	21	2	42	55	0.853	-0.118	3.776	0.01	0.007	0	46.4	39.6	74	142	125	0	34	33	34
2025	4	21	2	52	55	0.814	-0.072	3.776	0.013	0.01	0	46.9	39.6	74.8	143	125	0	34	33	33
2025	4	21	3	2	55	0.853	-0.108	3.776	0.013	0.01	0	46	39.1	74.4	142	124	0	35	33	34
2025	4	21	3	12	55	0.856	-0.102	3.776	0.013	0.01	0	46.4	39.6	73.5	142	125	0	34	33	34
2025	4	21	3	22	55	0.85	-0.121	3.776	0.01	0.007	0	46.4	39.6	74.4	142	125	0	34	33	33
2025	4	21	3	32	55	0.83	-0.072	3.776	0.016	0.013	0	46.9	39.6	74	143	125	0	34	33	34
2025	4	21	3	42	55	0.82	-0.066	3.776	0.013	0.01	0	46.4	39.6	74	143	125	0	35	33	34
2025	4	21	3	52	55	0.83	-0.082	3.776	0.01	0.007	0	46.4	40	74	142	125	0	34	32	34
2025	4	21	4	2	55	0.843	-0.089	3.776	0.013	0.01	0	46	38.7	74.4	142	124	0	35	34	34
2025	4	21	4	12	55	0.856	-0.102	3.776	0.01	0.007	0	46	39.1	74.4	141	124	0	34	33	34
2025	4	21	4	22	55	0.837	-0.085	3.776	0.013	0.01	0	46	39.1	74.8	141	124	0	34	33	33
2025	4	21	4	32	55	0.886	-0.112	3.776	0.013	0.01	0	46	39.1	75.3	141	124	0	34	33	33
2025	4	21	4	42	55	0.814	-0.095	3.776	0.016	0.016	0	45.6	39.6	74.8	141	125	0	35	33	34
2025	4	21	4	52	55	0.84	-0.131	3.776	0.01	0.007	0	45.2	39.6	75.3	140	124	0	35	32	34
2025	4	21	5	2	55	0.843	-0.085	3.776	0.013	0.01	0	45.6	38.7	75.3	140	123	0	34	33	33
2025	4	21	5	12	55	0.876	-0.072	3.776	0.01	0.007	0	45.2	38.3	74.8	139	123	0	34	34	34
2025	4	21	5	22	55	0.86	-0.121	3.776	0.01	0.007	0	45.2	38.7	74.4	139	123	0	34	33	34
2025	4	21	5	32	55	0.843	-0.085	3.776	0.013	0.01	0	45.2	38.3	74.4	139	122	0	34	33	34
2025	4	21	5	42	55	0.827	-0.082	3.776	0.01	0.007	0	44.7	38.3	75.7	138	122	0	34	33	33
2025	4	21	5	52	55	0.846	-0.085	3.776	0.01	0.007	0	44.3	37.8	76.1	137	121	0	34	33	33
2025	4	21	6	2	55	0.817	-0.062	3.776	0.013	0.01	0	43.9	37.4	74.8	136	120	0	34	33	34
2025	4	21	6	12	55	0.83	-0.079	3.776	0.01	0.007	0	43.9	37.8	75.7	136	121	0	34	33	33
2025	4	21	6	22	55	0.83	-0.085	3.78	0.013	0.01	0	43.4	37.4	75.3	135	119	0	34	32	34
2025	4	21	6	32	55	0.797	-0.102	3.78	0.01	0.007	0	43	36.1	76.1	134	118	0	34	34	34
2025	4	21	6	42	55	0.82	-0.098	3.78	0.01	0.007	0	42.6	37	75.3	134	119	0	35	33	33
2025	4	21	6	52	55	0.83	-0.089	3.78	0.01	0.007	0	42.6	37	75.7	134	119	0	35	33	34
2025	4	21	7	2	55	0.85	-0.112	3.78	0.01	0.007	0	42.6	37	76.1	133	119	0	34	33	34
2025	4	21	7	12	55	0.856	-0.105	3.78	0.013	0.01	0	42.1	37	75.7	133	119	0	35	33	34
2025	4	21	7	22	55	0.82	-0.115	3.78	0.01	0.007	0	42.1	37	76.1	133	119	0	35	33	34
2025	4	21	7	32	55	0.846	-0.135	3.78	0.013	0.01	0	42.1	37.4	76.5	133	119	0	35	32	34
2025	4	21	7	42	55	0.853	-0.118	3.78	0.013	0.01	0	43	37.4	75.7	134	120	0	34	33	34
2025	4	21	7	52	55	0.853	-0.072	3.78	0.013	0.01	0	43	37.4	76.1	134	120	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	21	8	2	55	0.85	-0.082	3.783	0.013	0.01	0	43	37.4	74	134	120	0	34	33	35
2025	4	21	8	12	55	0.807	-0.056	3.783	0.01	0.007	0	43.4	37.8	72.2	135	121	0	34	33	34
2025	4	21	8	22	55	0.807	-0.105	3.783	0.016	0.013	0	43.4	37.8	75.7	135	121	0	34	33	34
2025	4	21	8	32	55	0.807	-0.066	3.783	0.013	0.01	0	43.4	38.3	75.3	135	122	0	34	33	34
2025	4	21	8	42	55	0.85	-0.079	3.783	0.013	0.01	0	43	38.3	75.7	135	121	0	35	32	33
2025	4	21	8	52	55	0.846	-0.102	3.786	0.01	0.007	0	43.4	37.8	75.3	136	122	0	35	34	34
2025	4	21	9	2	55	0.82	-0.085	3.786	0.016	0.013	0	43.9	38.3	76.1	136	122	0	34	33	34
2025	4	21	9	12	55	0.823	-0.082	3.786	0.013	0.01	0	43.9	38.3	76.1	136	122	0	34	33	33
2025	4	21	9	22	55	0.833	-0.098	3.786	0.016	0.013	0	43.4	38.3	73.1	135	122	0	34	33	34
2025	4	21	16	15	24	24.6	-3.1	1.154	0.4	0.3	0	45.6	40.4	0	139	125	0	33	31	33
2025	4	21	16	25	24	24.7	-1.4	1.154	0.4	0.3	0	45.6	40.4	0	140	127	0	34	33	34
2025	4	21	16	35	24	26.7	-2.4	1.153	0.4	0.3	0	46	40.9	0	141	128	0	34	33	33
2025	4	21	16	45	24	25.6	-2.8	1.153	0.3	0.2	0	46	40.4	0	141	127	0	34	33	33
2025	4	21	16	55	24	25.1	-3	1.153	0.4	0.3	0	45.6	40.4	0	140	126	0	34	32	33
2025	4	21	17	5	24	25.6	-1.3	1.153	0.5	0.4	0	45.6	40.4	0	140	126	0	34	32	33
2025	4	21	17	15	24	26	-3.3	1.154	0.3	0.2	0	45.2	40.4	0	140	126	0	35	32	34
2025	4	21	17	25	24	24.6	-2.7	1.153	0.4	0.3	0	45.6	40.4	0	140	127	0	34	33	33
2025	4	21	17	35	24	24.5	-2	1.153	0.5	0.4	0	45.6	40.4	0	140	127	0	34	33	33
2025	4	21	17	45	24	25.4	-3.9	1.153	0.4	0.3	0	45.6	40.9	0	140	127	0	34	32	32
2025	4	21	17	55	24	25.2	-3.2	1.153	0.3	0.2	0	45.2	40	0	139	126	0	34	33	33
2025	4	21	18	5	24	25.4	-3.2	1.153	0.3	0.2	0	45.6	40	0	140	126	0	34	33	33
2025	4	21	18	15	24	25.4	-3.4	1.153	0.3	0.2	0	45.6	40.4	0	140	126	0	34	32	34
2025	4	21	18	25	24	24	-3.2	1.154	0.3	0.2	0	45.6	40.4	0	140	126	0	34	32	34
2025	4	21	18	35	24	25	-1.5	1.154	0.5	0.5	0	46	40.4	0	140	127	0	33	33	33
2025	4	21	18	45	24	25	-2.7	1.154	0.5	0.4	0	46	40.9	0	140	127	0	33	32	34
2025	4	21	18	55	24	25.4	-3.1	1.154	0.5	0.4	0	46	40.9	0	141	127	0	34	32	33
2025	4	21	19	5	24	27.2	-2.2	1.154	0.5	0.4	0	46	40.9	0	141	127	0	34	32	33
2025	4	21	19	15	24	25.3	-2.7	1.154	0.3	0.2	0	46	40.4	0	141	127	0	34	33	34
2025	4	21	19	25	24	25.9	-3	1.154	0.3	0.2	0	46	40.4	0	141	127	0	34	33	33
2025	4	21	19	35	24	24.8	-2.7	1.154	0.3	0.2	0	46	40	0	141	127	0	34	34	33
2025	4	21	19	45	24	24.5	-2.7	1.154	0.4	0.3	0	46	40.4	0	141	127	0	34	33	33
2025	4	21	19	55	24	25.3	-3	1.153	0.4	0.3	0	46.4	40.9	0	142	127	0	34	32	33
2025	4	21	20	5	24	24.7	-2.6	1.153	0.3	0.2	0	46.4	40.9	0	142	128	0	34	33	33
2025	4	21	20	15	24	26	-2.7	1.153	0.4	0.3	0	46.4	41.3	0	142	129	0	34	33	34
2025	4	21	20	25	24	24.4	-2.7	1.154	0.5	0.4	0	46.9	41.7	0	143	129	0	34	32	33
2025	4	21	20	35	24	26.2	-3	1.154	0.4	0.3	0	46.9	41.3	0	143	129	0	34	33	34
2025	4	21	20	45	24	25.1	-2.5	1.154	0.4	0.3	0	47.7	42.1	0	144	130	0	33	32	33
2025	4	21	20	55	24	25.8	-3.2	1.154	0.3	0.2	0	46.9	41.7	0	143	130	0	34	33	34
2025	4	21	21	5	24	26.1	-3.6	1.154	0.3	0.2	0	47.3	41.3	0	144	129	0	34	33	33
2025	4	21	21	15	24	24.7	-3.4	1.153	0.4	0.3	0	47.3	41.7	0	144	130	0	34	33	34
2025	4	21	21	25	24	25.3	-3.4	1.153	0.3	0.2	0	46.9	41.7	0	144	130	0	35	33	34
2025	4	21	21	35	24	25.3	-2.7	1.153	0.5	0.5	0	47.3	41.7	0	144	129	0	34	32	33
2025	4	21	21	45	24	25.9	-3.1	1.153	0.4	0.3	0	46.9	41.3	0	143	129	0	34	33	33
2025	4	21	21	55	24	25.6	-3	1.153	0.4	0.3	0	46.9	41.7	0	144	130	0	35	33	33
2025	4	21	22	5	24	25.8	-2.9	1.153	0.4	0.3	0	46.9	41.3	0	143	129	0	34	33	33
2025	4	21	22	15	24	26.4	-3.1	1.153	0.4	0.3	0	47.3	41.3	0	143	129	0	33	33	34
2025	4	21	22	25	24	25.3	-3.2	1.153	0.4	0.3	0	46.9	41.3	0	143	129	0	34	33	34
2025	4	21	22	35	24	25	-2.2	1.153	0.3	0.2	0	46.4	41.3	0	143	129	0	35	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	21	22	45	24	25.5	-2.7	1.153	0.4	0.3	0	46.9	40.9	0	143	128	0	34	33	34
2025	4	21	22	55	24	25.9	-3.1	1.153	0.3	0.2	0	47.3	41.7	0	143	129	0	33	32	34
2025	4	21	23	5	24	25.6	-2.6	1.153	0.4	0.3	0	46.9	41.3	0	143	129	0	34	33	33
2025	4	21	23	15	24	26.2	-2.8	1.153	0.5	0.4	0	46.9	41.3	0	143	129	0	34	33	35
2025	4	21	23	25	24	25.5	-3.5	1.153	0.3	0.2	0	46.9	41.3	0	143	129	0	34	33	33
2025	4	21	23	35	24	24.6	-3.7	1.153	0.4	0.3	0	47.3	41.3	0	144	129	0	34	33	34
2025	4	21	23	45	24	25.9	-3.1	1.153	0.4	0.3	0	47.3	41.3	0	144	129	0	34	33	34
2025	4	21	23	55	24	24.7	-2.7	1.153	0.4	0.3	0	46.9	41.7	0	144	130	0	35	33	34
2025	4	22	0	5	24	26.2	-3.6	1.153	0.3	0.2	0	47.3	41.3	0	144	129	0	34	33	33
2025	4	22	0	15	24	26.2	-3.6	1.153	0.4	0.3	0	47.3	41.7	0	144	130	0	34	33	34
2025	4	22	0	25	24	26.5	-2.5	1.153	0.5	0.4	0	46.9	41.7	0	143	129	0	34	32	33
2025	4	22	0	35	24	25.8	-2.1	1.153	0.5	0.4	0	46.9	41.7	0	144	130	0	35	33	34
2025	4	22	0	45	24	25.5	-2.6	1.153	0.3	0.2	0	46.9	41.3	0	143	129	0	34	33	34
2025	4	22	0	55	24	25.5	-3.4	1.153	0.4	0.3	0	46.9	41.3	0	144	129	0	35	33	33
2025	4	22	1	5	24	26.6	-2.6	1.153	0.4	0.3	0	47.3	41.3	0	144	129	0	34	33	34
2025	4	22	1	15	24	25.8	-3.4	1.153	0.3	0.2	0	47.7	41.7	0	145	130	0	34	33	34
2025	4	22	1	25	24	25.9	-2.2	1.153	0.4	0.3	0	47.3	41.3	0	144	130	0	34	34	34
2025	4	22	1	35	24	25.4	-3.5	1.153	0.5	0.4	0	47.3	41.3	0	144	129	0	34	33	34
2025	4	22	1	45	24	25.2	-3.5	1.153	0.4	0.3	0	47.3	41.3	0	144	129	0	34	33	34
2025	4	22	1	55	24	27.1	-3.5	1.153	0.3	0.2	0	46.9	41.3	0	143	129	0	34	33	33
2025	4	22	2	5	24	26.5	-2.6	1.153	0.5	0.5	0	46.9	41.3	0	143	129	0	34	33	34
2025	4	22	2	15	24	26.5	-3.3	1.153	0.3	0.2	0	46.9	41.3	0	143	129	0	34	33	33
2025	4	22	2	25	24	25.1	-2.7	1.153	0.4	0.3	0	47.3	41.3	0	144	129	0	34	33	34
2025	4	22	2	35	24	27.4	-2.7	1.153	0.4	0.3	0	46.9	41.7	0	143	129	0	34	32	34
2025	4	22	2	45	24	26.2	-2.5	1.153	0.5	0.4	0	46.9	40.4	0	143	128	0	34	34	34
2025	4	22	2	55	24	26.1	-2.4	1.153	0.3	0.2	0	46.4	40.9	0	142	128	0	34	33	34
2025	4	22	3	5	24	25.4	-2.2	1.153	0.5	0.4	0	46.9	41.3	0	143	128	0	34	32	34
2025	4	22	3	15	24	25.8	-3.2	1.153	0.4	0.3	0	46.4	41.3	0	143	129	0	35	33	33
2025	4	22	3	25	24	24.6	-3.1	1.153	0.4	0.3	0	46.9	41.3	0	143	129	0	34	33	34
2025	4	22	3	35	24	25	-3.4	1.153	0.5	0.4	0	46.9	41.3	0	143	129	0	34	33	34
2025	4	22	3	45	24	25.5	-2.2	1.153	0.5	0.4	0	46.9	41.7	0	143	130	0	34	33	33
2025	4	22	3	55	24	25.7	-3.1	1.153	0.3	0.2	0	46.4	41.3	0	143	129	0	35	33	33
2025	4	22	4	5	24	25.4	-2.6	1.153	0.4	0.3	0	46.9	41.3	0	143	129	0	34	33	33
2025	4	22	4	15	24	26.3	-3.2	1.153	0.4	0.3	0	47.3	41.3	0	144	129	0	34	33	33
2025	4	22	4	25	24	25.5	-3.4	1.153	0.3	0.2	0	46.9	41.3	0	144	129	0	35	33	34
2025	4	22	4	35	24	25.3	-3.5	1.153	0.4	0.3	0	46.9	41.3	0	143	129	0	34	33	33
2025	4	22	4	45	24	23.9	-1.8	1.153	0.3	0.2	0	46.4	42.1	0	143	130	0	35	32	33
2025	4	22	4	55	24	25.9	-2.9	1.153	0.4	0.3	0	46.9	41.7	0	143	129	0	34	32	33
2025	4	22	5	5	24	25.4	-3.3	1.153	0.3	0.2	0	46.9	41.3	0	143	129	0	34	33	34
2025	4	22	5	15	24	26.3	-4.1	1.153	0.4	0.3	0	46.9	41.3	0	143	129	0	34	33	34
2025	4	22	5	25	24	25.5	-2.7	1.153	0.5	0.4	0	47.3	41.7	0	144	129	0	34	32	33
2025	4	22	5	35	24	25.1	-2.7	1.154	0.5	0.4	0	46.9	40.9	0	143	129	0	34	34	34
2025	4	22	5	45	24	25.9	-2.2	1.154	0.3	0.2	0	46.9	41.3	0	143	129	0	34	33	33
2025	4	22	5	55	24	25.5	-2.9	1.154	0.3	0.2	0	46.9	41.7	0	143	129	0	34	32	34
2025	4	22	6	5	24	25.9	-3.5	1.154	0.4	0.3	0	46.9	41.3	0	143	129	0	34	33	34
2025	4	22	6	15	24	25.5	-3.6	1.154	0.4	0.3	0	46.4	40.9	0	142	128	0	34	33	34
2025	4	22	6	25	24	24.8	-2.1	1.154	0.4	0.3	0	45.6	40.4	0	141	127	0	35	33	34
2025	4	22	6	35	24	26.1	-2.9	1.154	0.4	0.3	0	46	40.9	0	141	127	0	34	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	22	6	45	24	25.7	-3.3	1.154	0.4	0.3	0	46	40	0	140	126	0	33	33	34
2025	4	22	6	55	24	25.8	-2.1	1.154	0.4	0.3	0	45.2	40	0	139	125	0	34	32	34
2025	4	22	7	5	24	25.1	-3.4	1.154	0.3	0.2	0	44.7	39.1	0	139	125	0	35	34	33
2025	4	22	7	15	24	25.9	-3.2	1.154	0.5	0.4	0	45.2	39.6	0	139	125	0	34	33	34
2025	4	22	7	25	24	25.6	-2.6	1.154	0.4	0.3	0	44.7	39.6	0	138	125	0	34	33	34
2025	4	22	7	35	24	25.8	-2.6	1.154	0.4	0.3	0	44.7	39.1	0	138	124	0	34	33	33
2025	4	22	7	45	24	25.8	-2.9	1.154	0.5	0.4	0	44.7	39.1	0	138	124	0	34	33	35
2025	4	22	7	55	24	24.9	-3.1	1.154	0.5	0.4	0	44.3	39.1	0	137	124	0	34	33	33
2025	4	22	8	5	24	24.7	-3.2	1.154	0.5	0.4	0	44.7	39.6	0	138	124	0	34	32	33
2025	4	22	8	15	24	26	-2.3	1.155	0.4	0.3	0	44.7	39.6	0	138	124	0	34	32	34
2025	4	22	8	25	24	25.2	-2.3	1.155	0.4	0.3	0	45.2	40	0	138	125	0	33	32	34
2025	4	22	8	35	24	25.7	-3.3	1.155	0.4	0.3	0	44.7	39.6	0	138	125	0	34	33	34
2025	4	22	8	45	24	25.9	-2.8	1.155	0.3	0.2	0	45.2	39.6	0	139	125	0	34	33	34
2025	4	22	8	55	24	26.4	-3.1	1.155	0.4	0.3	0	44.3	40	0	138	125	0	35	32	34
2025	4	22	9	5	24	26.2	-3	1.155	0.4	0.3	0	44.7	39.1	0	138	124	0	34	33	34
2025	4	22	9	15	24	24.7	-2.6	1.155	0.3	0.2	0	44.7	39.6	0	138	125	0	34	33	34
2025	4	22	9	25	24	26.5	-2.2	1.156	0.3	0.2	0	44.7	40	0	138	125	0	34	32	34
2025	4	22	9	35	24	26.3	-3.4	1.156	0.4	0.3	0	45.2	40	0	139	126	0	34	33	33
2025	4	22	9	45	24	25.9	-3.6	1.156	0.3	0.2	0	45.2	40	0	139	126	0	34	33	34
2025	4	22	9	55	24	25.9	-2.6	1.156	0.5	0.5	0	45.2	40	0	139	126	0	34	33	33
2025	4	22	10	5	24	24.9	-3.1	1.156	0.3	0.2	0	45.2	40	0	139	126	0	34	33	34
2025	4	22	10	15	24	25.3	-2.4	1.156	0.3	0.2	0	44.7	39.6	0	138	125	0	34	33	33
2025	4	22	10	25	24	25.4	-3.6	1.156	0.5	0.4	0	44.3	39.1	0	137	124	0	34	33	34
2025	4	22	10	35	24	25.2	-1.8	1.156	0.5	0.4	0	44.7	40	0	139	126	0	35	33	34
2025	4	22	10	45	24	25.5	-3.2	1.156	0.5	0.4	0	44.3	40	0	138	125	0	35	32	34
2025	4	22	10	55	24	25	-3.1	1.156	0.3	0.2	0	44.7	40	0	138	125	0	34	32	33
2025	4	22	11	5	24	24.9	-4	1.156	0.4	0.3	0	45.2	39.6	0	138	125	0	33	33	33
2025	4	22	11	15	24	25.3	-2.8	1.157	0.4	0.3	0	44.7	39.6	0	138	125	0	34	33	34
2025	4	22	11	25	24	26.3	-3.5	1.157	0.4	0.3	0	44.7	39.6	0	137	124	0	33	32	34
2025	4	22	11	35	24	24.5	-3.3	1.156	0.3	0.2	0	45.2	40	0	139	126	0	34	33	33
2025	4	22	11	45	24	26	-3.3	1.156	0.5	0.5	0	44.3	39.6	0	137	124	0	34	32	33
2025	4	22	11	55	24	26.7	-2.6	1.157	0.3	0.2	0	44.3	39.6	0	137	125	0	34	33	33
2025	4	22	12	5	24	24.8	-2.7	1.156	0.5	0.4	0	44.3	39.6	0	137	124	0	34	32	33
2025	4	22	12	15	24	25.7	-2.6	1.157	0.3	0.2	0	44.3	39.6	0	137	125	0	34	33	34
2025	4	22	12	25	24	25.2	-2.6	1.156	0.4	0.3	0	44.3	39.6	0	137	124	0	34	32	34
2025	4	22	12	35	24	24.8	-2.5	1.156	0.4	0.3	0	44.7	39.6	0	138	125	0	34	33	34
2025	4	22	12	45	24	25.9	-1.9	1.156	0.5	0.4	0	45.2	40.4	0	138	126	0	33	32	33
2025	4	22	12	55	24	24.6	-2.1	1.156	0.3	0.2	0	44.7	40	0	138	126	0	34	33	33
2025	4	22	13	5	24	24.6	-2.3	1.157	0.3	0.2	0	44.7	40	0	138	125	0	34	32	33
2025	4	22	13	15	24	25.4	-2.6	1.156	0.3	0.2	0	44.7	40.4	0	138	126	0	34	32	33
2025	4	22	13	25	24	25.3	-3.2	1.156	0.3	0.2	0	44.7	39.6	0	138	125	0	34	33	33
2025	4	22	13	35	24	25.3	-3.2	1.155	0.4	0.3	0	46	40.4	0	140	127	0	33	33	33
2025	4	22	13	45	24	24.6	-3.2	1.154	0.4	0.3	0	44.7	39.6	0	138	125	0	34	33	33
2025	4	22	13	55	24	25.3	-2	1.155	0.4	0.3	0	45.2	40	0	139	126	0	34	33	34
2025	4	22	14	5	24	25.4	-3.4	1.156	0.4	0.3	0	44.7	40.4	0	139	126	0	35	32	33
2025	4	22	14	15	24	24.5	-2.5	1.156	0.5	0.5	0	45.6	40	0	139	126	0	33	33	33
2025	4	22	14	25	24	25.5	-2.3	1.155	0.5	0.4	0	45.2	40	0	139	126	0	34	33	33
2025	4	22	14	35	24	24.4	-2.3	1.156	0.3	0.2	0	45.6	40.4	0	139	126	0	33	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	22	14	45	24	25.1	-2.7	1.155	0.4	0.3	0	45.2	40	0	139	126	0	34	33	33
2025	4	22	14	55	24	24.7	-1.7	1.156	0.3	0.2	0	44.7	40	0	138	126	0	34	33	34
2025	4	22	15	5	24	25.8	-2.9	1.155	0.4	0.3	0	45.2	40.4	0	139	127	0	34	33	34
2025	4	22	15	15	24	24.4	-2.8	1.155	0.5	0.4	0	45.6	40.4	0	139	126	0	33	32	33
2025	4	22	15	25	24	25	-2.3	1.155	0.3	0.2	0	44.7	40.4	0	138	126	0	34	32	34
2025	4	22	15	35	24	24.6	-2.7	1.155	0.3	0.2	0	45.2	40.9	0	139	127	0	34	32	34
2025	4	22	15	45	24	25	-2.3	1.156	0.4	0.3	0	45.2	40.9	0	139	127	0	34	32	33
2025	4	22	15	55	24	25.4	-2.1	1.153	0.3	0.2	0	45.2	40.4	0	139	126	0	34	32	34
2025	4	22	16	5	24	25.8	-3.1	1.155	0.3	0.2	0	45.2	39.6	0	138	125	0	33	33	33
2025	4	22	16	15	24	24.6	-2.4	1.156	0.3	0.2	0	44.7	40.4	0	138	126	0	34	32	34
2025	4	22	16	25	24	25.3	-2.7	1.154	0.4	0.3	0	45.2	39.6	0	138	125	0	33	33	32
2025	4	22	16	35	24	25.6	-2.1	1.154	0.4	0.3	0	44.7	39.6	0	138	125	0	34	33	33
2025	4	22	16	45	24	25.6	-3.4	1.154	0.3	0.2	0	44.7	40	0	138	125	0	34	32	33
2025	4	22	16	55	24	26	-2.7	1.154	0.4	0.3	0	44.7	39.6	0	138	125	0	34	33	34
2025	4	22	17	5	24	25.7	-3.2	1.154	0.3	0.2	0	45.2	40	0	138	125	0	33	32	33
2025	4	22	17	15	24	25.1	-3.7	1.155	0.4	0.3	0	44.3	40	0	137	125	0	34	32	34
2025	4	22	17	25	24	26	-2.5	1.154	0.4	0.3	0	44.3	39.6	0	137	125	0	34	33	33
2025	4	22	17	35	24	24.7	-2.2	1.155	0.4	0.3	0	45.2	39.6	0	138	125	0	33	33	33
2025	4	22	17	45	24	25.7	-3.6	1.154	0.4	0.3	0	45.2	40	0	138	125	0	33	32	34
2025	4	22	17	55	24	25.4	-3.1	1.153	0.5	0.4	0	44.3	39.6	0	137	124	0	34	32	33
2025	4	22	18	5	24	25.8	-2.1	1.153	0.5	0.4	0	44.3	39.1	0	137	124	0	34	33	33
2025	4	22	18	15	24	26.1	-2.2	1.153	0.4	0.3	0	44.7	39.6	0	138	125	0	34	33	33
2025	4	22	18	25	24	25.9	-2.1	1.154	0.4	0.3	0	44.3	40	0	137	125	0	34	32	33
2025	4	22	18	35	24	25.7	-2.7	1.153	0.4	0.3	0	44.7	40	0	138	125	0	34	32	33
2025	4	22	18	45	24	25.9	-2.7	1.154	0.4	0.3	0	44.7	39.6	0	138	125	0	34	33	32
2025	4	22	18	55	24	25.9	-3.7	1.155	0.3	0.2	0	44.7	40	0	138	125	0	34	32	33
2025	4	22	19	5	24	25.6	-2.4	1.154	0.4	0.3	0	44.7	40.4	0	138	126	0	34	32	33
2025	4	22	19	15	24	25.4	-2.6	1.155	0.4	0.3	0	44.7	40	0	138	125	0	34	32	34
2025	4	22	19	25	24	26.5	-2.8	1.155	0.4	0.3	0	45.2	40	0	138	126	0	33	33	34
2025	4	22	19	35	24	24.8	-2	1.155	0.3	0.2	0	45.2	40	0	139	126	0	34	33	33
2025	4	22	19	45	24	25.7	-2.7	1.155	0.5	0.4	0	45.2	40.4	0	139	126	0	34	32	33
2025	4	22	19	55	24	26.3	-1.5	1.155	0.4	0.3	0	44.7	40.4	0	139	127	0	35	33	34
2025	4	22	20	5	24	25.4	-3.4	1.155	0.5	0.4	0	46	41.3	0	141	128	0	34	32	34
2025	4	22	20	15	24	25.1	-1.9	1.155	0.4	0.3	0	46	40.9	0	141	128	0	34	33	34
2025	4	22	20	25	24	25.7	-2.9	1.155	0.4	0.3	0	46	41.7	0	141	129	0	34	32	33
2025	4	22	20	35	24	26	-3.2	1.154	0.3	0.2	0	46	41.3	0	141	129	0	34	33	33
2025	4	22	20	45	24	26.4	-2.6	1.154	0.4	0.3	0	46	41.7	0	141	129	0	34	32	34
2025	4	22	20	55	24	26.7	-2.4	1.154	0.5	0.4	0	46.9	41.3	0	142	129	0	33	33	33
2025	4	22	21	5	24	25.5	-3.4	1.154	0.3	0.2	0	46	41.3	0	141	129	0	34	33	34
2025	4	22	21	15	24	25.1	-3	1.154	0.4	0.3	0	46	41.3	0	141	128	0	34	32	34
2025	4	22	21	25	24	25.7	-2.7	1.154	0.4	0.3	0	46.9	41.3	0	143	129	0	34	33	33
2025	4	22	21	35	24	24.9	-3.1	1.154	0.4	0.3	0	46.9	41.7	0	143	129	0	34	32	34
2025	4	22	21	45	24	26.3	-2.8	1.154	0.3	0.2	0	46.9	41.3	0	143	129	0	34	33	33
2025	4	22	21	55	24	26.5	-3.1	1.154	0.5	0.4	0	46.9	40.9	0	143	129	0	34	34	33
2025	4	22	22	5	24	24	-3	1.153	0.3	0.2	0	47.3	41.7	0	143	129	0	33	32	34
2025	4	22	22	15	24	25.4	-3	1.154	0.5	0.4	0	46.9	40.9	0	143	128	0	34	33	33
2025	4	22	22	25	24	26.2	-3.3	1.154	0.3	0.2	0	46.9	41.3	0	143	129	0	34	33	34
2025	4	22	22	35	24	25.1	-2.8	1.154	0.3	0.2	0	46.9	41.7	0	143	129	0	34	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	22	22	45	24	26.4	-3.1	1.154	0.3	0.2	0	46.9	41.3	0	142	128	0	33	32	33
2025	4	22	22	55	24	25.1	-2.5	1.154	0.3	0.2	0	46.4	41.3	0	142	129	0	34	33	33
2025	4	22	23	5	24	25.6	-2.8	1.154	0.5	0.4	0	46.9	41.3	0	143	129	0	34	33	33
2025	4	22	23	15	24	24.9	-2.8	1.154	0.3	0.2	0	46.9	41.3	0	143	129	0	34	33	33
2025	4	22	23	25	24	26	-2.9	1.154	0.4	0.3	0	46.9	41.7	0	143	129	0	34	32	33
2025	4	22	23	35	24	25.2	-2.7	1.153	0.3	0.2	0	46.9	41.7	0	143	129	0	34	32	33
2025	4	22	23	45	24	25.5	-3.6	1.154	0.4	0.3	0	46.9	40.9	0	143	128	0	34	33	34
2025	4	22	23	55	24	26.5	-3.1	1.154	0.4	0.3	0	46.9	41.3	0	143	129	0	34	33	33
2025	4	23	0	5	24	26.2	-1.7	1.153	0.5	0.4	0	46.9	41.3	0	143	129	0	34	33	33
2025	4	23	0	15	24	25.3	-2.8	1.154	0.3	0.2	0	46.9	40.9	0	143	128	0	34	33	34
2025	4	23	0	25	24	25.4	-2	1.153	0.4	0.3	0	46.9	41.3	0	143	129	0	34	33	33
2025	4	23	0	35	24	26.1	-3.1	1.153	0.4	0.3	0	46.4	41.3	0	142	129	0	34	33	34
2025	4	23	0	45	24	26.1	-2.9	1.153	0.5	0.4	0	46.9	41.3	0	143	129	0	34	33	34
2025	4	23	0	55	24	26.5	-2.2	1.153	0.3	0.2	0	46.4	40.9	0	142	128	0	34	33	34
2025	4	23	1	5	24	25.5	-2.4	1.153	0.4	0.3	0	46	41.3	0	142	129	0	35	33	33
2025	4	23	1	15	24	26.7	-3.5	1.153	0.4	0.3	0	46.4	40.9	0	142	128	0	34	33	34
2025	4	23	1	25	24	25	-2.9	1.153	0.4	0.3	0	46	41.3	0	142	129	0	35	33	34
2025	4	23	1	35	24	25.2	-2.4	1.153	0.4	0.3	0	46.4	41.3	0	142	129	0	34	33	34
2025	4	23	1	45	24	24.8	-1.8	1.153	0.4	0.3	0	46	41.3	0	142	129	0	35	33	33
2025	4	23	1	55	24	24.3	-2	1.153	0.4	0.3	0	46.4	41.7	0	142	129	0	34	32	34
2025	4	23	2	5	24	25.5	-3.1	1.153	0.3	0.2	0	46.4	40.9	0	142	128	0	34	33	34
2025	4	23	2	15	24	25.2	-2.6	1.153	0.4	0.3	0	46.4	41.3	0	142	129	0	34	33	34
2025	4	23	2	25	24	26.4	-3.1	1.153	0.3	0.2	0	46	41.3	0	141	128	0	34	32	34
2025	4	23	2	35	24	26	-2.9	1.153	0.3	0.2	0	46.4	40.9	0	141	128	0	33	33	33
2025	4	23	2	45	24	25.1	-3.1	1.153	0.5	0.4	0	46.4	41.3	0	142	128	0	34	32	33
2025	4	23	2	55	24	25.7	-3.5	1.153	0.4	0.3	0	46.4	41.3	0	142	128	0	34	32	33
2025	4	23	3	5	24	23.2	-1.6	1.153	0.4	0.3	0	46.4	41.3	0	142	129	0	34	33	34
2025	4	23	3	15	24	25.7	-3.1	1.153	0.3	0.2	0	46.9	40.9	0	142	128	0	33	33	33
2025	4	23	3	25	24	26	-2.9	1.153	0.5	0.5	0	46	40.9	0	141	128	0	34	33	32
2025	4	23	3	35	24	26.1	-2	1.153	0.5	0.4	0	46	40.9	0	141	128	0	34	33	34
2025	4	23	3	45	24	25.3	-3.2	1.153	0.5	0.4	0	46	40.9	0	141	128	0	34	33	34
2025	4	23	3	55	24	23.8	-3.4	1.153	0.4	0.3	0	46	40.9	0	141	128	0	34	33	34
2025	4	23	4	5	24	25.8	-2.7	1.153	0.3	0.2	0	46	40.4	0	141	128	0	34	34	33
2025	4	23	4	15	24	25.4	-3.1	1.153	0.4	0.3	0	46	40.9	0	141	128	0	34	33	34
2025	4	23	4	25	24	25.2	-2.7	1.153	0.3	0.2	0	46	40.9	0	141	128	0	34	33	34
2025	4	23	4	35	24	25.1	-3	1.153	0.4	0.3	0	46.4	40.9	0	141	128	0	33	33	33
2025	4	23	4	45	24	26	-2.2	1.153	0.4	0.3	0	46	40.9	0	141	128	0	34	33	33
2025	4	23	4	55	24	25.8	-2.4	1.154	0.3	0.2	0	46	41.3	0	141	128	0	34	32	34
2025	4	23	5	5	24	24.9	-2.3	1.154	0.4	0.3	0	46	41.3	0	141	129	0	34	33	34
2025	4	23	5	15	24	25.9	-2.6	1.154	0.3	0.2	0	46	40.9	0	141	128	0	34	33	34
2025	4	23	5	25	24	24.9	-1.7	1.154	0.4	0.3	0	46	40.9	0	141	128	0	34	33	33
2025	4	23	5	35	24	25.9	-2.6	1.154	0.6	0.5	0	46	41.3	0	141	128	0	34	32	33
2025	4	23	5	45	24	25.4	-3.1	1.154	0.4	0.3	0	46	41.3	0	141	128	0	34	32	33
2025	4	23	5	55	24	25.1	-2.5	1.154	0.4	0.3	0	45.6	40.4	0	140	127	0	34	33	34
2025	4	23	6	5	24	26.6	-3.1	1.154	0.5	0.5	0	45.6	40.9	0	140	128	0	34	33	34
2025	4	23	6	15	24	24.4	-2.5	1.154	0.4	0.3	0	46	40.4	0	141	127	0	34	33	33
2025	4	23	6	25	24	26.5	-1.8	1.154	0.4	0.3	0	45.6	40.9	0	140	127	0	34	32	34
2025	4	23	6	35	24	24.5	-3.1	1.154	0.5	0.4	0	45.6	40.9	0	140	127	0	34	32	34

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	4	23	6	45	24	25.7	-2.6	1.154	0.5	0.5	0	45.2	40	0	139	127	0	34	34	33	
2025	4	23	6	55	24	26	-2.9	1.154	0.4	0.3	0	44.7	40	0	138	126	0	34	33	33	
2025	4	23	7	5	24	25.2	-2.3	1.155	0.4	0.3	0	44.7	40	0	138	126	0	34	33	33	
2025	4	23	7	15	24	25.2	-1.9	1.155	0.4	0.3	0	45.2	40	0	139	126	0	34	33	33	
2025	4	23	7	25	24	26.5	-2.4	1.155	0.3	0.2	0	44.7	40	0	138	125	0	34	32	34	
2025	4	23	7	35	24	25.9	-2.6	1.155	0.3	0.2	0	44.7	39.6	0	138	125	0	34	33	33	
2025	4	23	7	45	24	25.8	-2.7	1.155	0.5	0.4	0	44.7	39.6	0	138	125	0	34	33	33	
2025	4	23	7	55	24	26.2	-2.6	1.155	0.5	0.4	0	44.7	39.6	0	138	125	0	34	33	34	
2025	4	23	8	5	24	24.2	-2.4	1.155	0.3	0.2	0	44.7	40	0	138	125	0	34	32	33	
2025	4	23	8	15	24	25.3	-3.5	1.155	0.5	0.4	0	44.7	40	0	138	125	0	34	32	33	
2025	4	23	8	25	24	26	-3.6	1.155	0.4	0.3	0	44.3	39.6	0	137	124	0	34	32	33	
2025	4	23	8	35	24	25.6	-2	1.155	0.4	0.3	0	44.7	40.4	0	138	126	0	34	32	33	
2025	4	23	8	45	24	25.5	-1.9	1.156	0.3	0.2	0	44.7	40.4	0	138	126	0	34	32	34	
2025	4	23	8	55	24	25.8	-2.8	1.155	0.3	0.2	0	44.3	39.1	0	137	124	0	34	33	34	
2025	4	23	9	5	24	26	-3.1	1.155	0.5	0.4	0	44.3	39.1	0	137	124	0	34	33	33	
2025	4	23	9	15	24	25.3	-2.3	1.156	0.4	0.3	0	44.7	40	0	137	125	0	33	32	34	
2025	4	23	9	25	24	24.7	-2.3	1.156	0.4	0.3	0	44.7	39.6	0	138	125	0	34	33	33	
2025	4	23	9	35	24	25	-2	1.156	0.4	0.3	0	45.6	40.9	0	140	128	0	34	33	33	
2025	4	23	9	45	24	24.1	-2.6	1.156	0.5	0.4	0	44.7	40	0	138	126	0	34	33	33	
2025	4	23	9	55	24	25.8	-3.3	1.156	0.3	0.2	0	44.3	40	0	137	125	0	34	32	34	
2025	4	23	10	5	24	25.3	-2.5	1.156	0.4	0.3	0	44.3	39.6	0	137	125	0	34	33	33	
2025	4	23	10	15	24	25.6	-2.8	1.156	0.3	0.2	0	44.3	39.6	0	137	125	0	34	33	34	
2025	4	23	10	25	24	25.3	-3.3	1.156	0.5	0.4	0	44.3	40	0	137	125	0	34	32	34	
2025	4	23	10	35	24	25.7	-3.6	1.156	0.3	0.2	0	43.9	39.6	0	136	124	0	34	32	34	
2025	4	23	10	45	24	25.5	-2.5	1.156	0.5	0.4	0	44.3	39.1	0	136	124	0	33	33	33	
2025	4	23	10	55	24	25.3	-1.7	1.156	0.3	0.2	0	44.3	39.6	0	137	125	0	34	33	33	
2025	4	23	11	5	24	25	-3.5	1.156	0.4	0.3	0	44.3	40	0	137	125	0	34	32	34	
2025	4	23	11	15	24	25.9	-3.9	1.156	0.4	0.3	0	43.9	38.7	0	136	123	0	34	33	33	
2025	4	23	11	25	24	26.7	-2.7	1.156	0.3	0.2	0	43.9	38.7	0	135	123	0	33	33	33	
2025	4	23	11	35	24	24.4	-1.6	1.156	0.4	0.3	0	43.9	39.1	0	136	124	0	34	33	34	
2025	4	23	11	45	24	25.8	-2.7	1.156	0.4	0.3	0	44.3	38.7	0	136	123	0	33	33	33	
2025	4	23	11	55	24	25.3	-3.7	1.156	0.4	0.3	0	43.4	38.7	0	135	123	0	34	33	33	
2025	4	23	12	5	24	26.1	-3.1	1.156	0.4	0.3	0	43.9	39.6	0	136	124	0	34	32	33	
2025	4	23	12	15	24	25	-2.8	1.156	0.5	0.4	0	43.9	39.6	0	136	124	0	34	32	32	
2025	4	23	12	25	24	27.3	-2.7	1.156	0.3	0.2	0	43.4	39.1	0	135	123	0	34	32	33	
2025	4	23	12	35	24	24.7	-2.2	1.155	0.3	0.2	0	43.9	39.6	0	136	124	0	34	32	33	
2025	4	23	12	45	24	26.1	-3.6	1.155	0.3	0.2	0	43.9	39.6	0	136	124	0	34	32	33	
2025	4	23	12	55	24	25	-2.8	1.155	0.4	0.3	0	44.3	39.1	0	136	124	0	33	33	33	
2025	4	23	13	5	24	24.4	-2.3	1.154	0.3	0.2	0	44.3	39.6	0	136	124	0	33	32	33	
2025	4	23	13	15	24	26.4	-2.7	1.153	0.3	0.2	0	44.3	39.6	0	136	124	0	33	32	33	
2025	4	23	13	25	24	25.9	-2.7	1.153	0.3	0.2	0	43.9	40	0	136	124	0	34	31	33	
2025	4	23	13	35	24	25.5	-2.7	1.153	0.3	0.2	0	44.3	39.6	0	136	124	0	33	32	33	
2025	4	23	13	45	24	24.8	-1.9	1.154	0.4	0.3	0	44.3	39.1	0	136	124	0	33	33	33	
2025	4	23	13	55	24	25.5	-3	1.153	0.3	0.2	0	43.4	39.1	0	135	123	0	34	32	33	
2025	4	23	14	5	24	25.4	-2.8	1.153	0.4	0.3	0	43.4	39.1	0	135	123	0	34	32	33	
2025	4	23	14	15	24	25.7	-2.3	1.153	0.3	0.2	0	43.9	39.1	0	135	123	0	33	32	32	
2025	4	23	14	25	24	25.5	-3.1	1.153	0.3	0.2	0	43.4	39.1	0	135	123	0	34	32	33	
2025	4	23	14	35	24	26	-2.7	1.153	0.4	0.3	0	43.4	39.1	0	135	123	0	34	32	32	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	23	14	45	24	25.5	-2.4	1.153	0.3	0.2	0	43.9	39.6	0	136	124	0	34	32	33
2025	4	23	14	55	24	25.7	-3.8	1.153	0.3	0.2	0	43.4	39.6	0	135	124	0	34	32	33
2025	4	23	15	5	24	26.5	-2.3	1.153	0.5	0.4	0	44.3	39.6	0	136	124	0	33	32	33
2025	4	23	15	15	24	25.2	-2.5	1.153	0.3	0.2	0	44.3	40	0	136	125	0	33	32	33
2025	4	23	15	25	24	25.7	-2.7	1.153	0.4	0.3	0	44.3	39.6	0	136	124	0	33	32	33
2025	4	23	15	35	24	25.6	-2.4	1.153	0.4	0.3	0	43.9	39.6	0	136	125	0	34	33	33
2025	4	23	15	45	24	26.3	-1.4	1.153	0.5	0.4	0	43.9	40	0	137	125	0	35	32	33
2025	4	23	15	55	24	27	-2.9	1.153	0.3	0.2	0	44.3	40	0	137	125	0	34	32	33
2025	4	23	16	5	24	26.9	-2.7	1.153	0.3	0.2	0	44.7	39.6	0	137	125	0	33	33	33
2025	4	23	16	15	24	26	-4.1	1.153	0.3	0.2	0	44.3	40	0	137	125	0	34	32	33
2025	4	23	16	25	24	25.6	-1.7	1.153	0.4	0.3	0	43.4	38.3	0	135	121	0	34	32	34
2025	4	23	16	35	24	25.2	-2.3	1.153	0.4	0.3	0	44.7	38.7	0	137	123	0	33	33	33
2025	4	23	16	45	24	24.6	-2.7	1.153	0.4	0.3	0	44.7	39.1	0	137	123	0	33	32	33
2025	4	23	16	55	24	24.7	-2	1.152	0.4	0.3	0	44.7	39.1	0	137	123	0	33	32	34
2025	4	23	17	5	24	26.1	-3.4	1.153	0.4	0.3	0	44.3	38.7	0	136	122	0	33	32	33
2025	4	23	17	15	24	25.8	-2.9	1.153	0.4	0.3	0	44.7	38.3	0	137	122	0	33	33	33
2025	4	23	17	25	24	25.4	-2.7	1.152	0.4	0.3	0	44.3	39.1	0	137	123	0	34	32	34
2025	4	23	17	35	24	26	-2.7	1.152	0.3	0.2	0	44.3	39.1	0	137	123	0	34	32	33
2025	4	23	17	45	24	25.1	-2.4	1.152	0.4	0.3	0	44.7	39.1	0	137	123	0	33	32	33
2025	4	23	17	55	24	26.8	-3.2	1.152	0.4	0.3	0	44.7	38.3	0	137	122	0	33	33	33
2025	4	23	18	5	24	26.4	-2.6	1.152	0.3	0.2	0	44.3	38.3	0	136	122	0	33	33	33
2025	4	23	18	15	24	26.6	-2.4	1.152	0.3	0.2	0	44.3	38.7	0	137	122	0	34	32	33
2025	4	23	18	25	24	24.7	-2.2	1.152	0.5	0.4	0	44.3	38.7	0	137	123	0	34	33	33
2025	4	23	18	35	24	24.8	-0.9	1.152	0.4	0.3	0	44.7	39.1	0	138	123	0	34	32	33
2025	4	23	18	45	24	26.8	-3.2	1.153	0.3	0.2	0	44.3	39.6	0	137	123	0	34	31	33
2025	4	23	18	55	24	25.8	-2.3	1.152	0.4	0.3	0	44.7	39.1	0	137	123	0	33	32	34
2025	4	23	19	5	24	25.7	-1.8	1.152	0.5	0.4	0	44.7	39.1	0	138	123	0	34	32	33
2025	4	23	19	15	24	25.6	-3.2	1.152	0.3	0.2	0	44.7	39.1	0	138	123	0	34	32	33
2025	4	23	19	25	24	26.1	-2.7	1.152	0.4	0.3	0	44.7	39.1	0	138	124	0	34	33	33
2025	4	23	19	35	24	27.1	-3.2	1.152	0.4	0.3	0	45.2	39.1	0	139	124	0	34	33	33
2025	4	23	19	45	24	25	-2.3	1.152	0.3	0.2	0	45.6	39.6	0	140	125	0	34	33	33
2025	4	23	19	55	24	25.7	-2.7	1.152	0.4	0.3	0	45.6	40.4	0	140	126	0	34	32	33
2025	4	23	20	5	24	25.8	-2.8	1.152	0.4	0.3	0	46.4	40.9	0	141	127	0	33	32	33
2025	4	23	20	15	24	25.3	-1.6	1.152	0.4	0.3	0	46.4	40.4	0	142	127	0	34	33	33
2025	4	23	20	25	24	26.4	-2.7	1.151	0.3	0.2	0	46.4	40.9	0	142	128	0	34	33	33
2025	4	23	20	35	24	26.2	-3.2	1.152	0.4	0.3	0	46.4	40.9	0	142	127	0	34	32	33
2025	4	23	20	45	24	26.7	-2.2	1.151	0.3	0.2	0	46.4	41.3	0	141	128	0	33	32	33
2025	4	23	20	55	24	26.1	-3.1	1.151	0.3	0.2	0	46	40.9	0	141	127	0	34	32	34
2025	4	23	21	5	24	26.6	-3.4	1.151	0.4	0.3	0	46.4	40.9	0	141	127	0	33	32	33
2025	4	23	21	15	24	26.8	-3.5	1.152	0.4	0.3	0	46.4	40.9	0	141	127	0	33	32	33
2025	4	23	21	25	24	26.3	-3.6	1.151	0.3	0.2	0	46	40.9	0	141	127	0	34	32	33
2025	4	23	21	35	24	25.6	-3.9	1.151	0.4	0.3	0	46	40.9	0	141	127	0	34	32	34
2025	4	23	21	45	24	26.4	-2.9	1.152	0.5	0.4	0	46	40.4	0	141	127	0	34	33	33
2025	4	23	21	55	24	25.5	-2.7	1.152	0.3	0.2	0	46	40.9	0	141	127	0	34	32	33
2025	4	23	22	5	24	25.8	-2.8	1.152	0.4	0.3	0	46	40.4	0	141	127	0	34	33	33
2025	4	23	22	15	24	24.6	-2.6	1.152	0.5	0.4	0	46	40.9	0	141	127	0	34	32	33
2025	4	23	22	25	24	26.6	-2.8	1.152	0.4	0.3	0	45.6	40	0	140	126	0	34	33	34
2025	4	23	22	35	24	25.9	-1.6	1.152	0.3	0.2	0	45.6	40.9	0	140	127	0	34	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	23	22	45	24	26.2	-1.8	1.153	0.4	0.3	0	45.2	40.4	0	140	126	0	35	32	34
2025	4	23	22	55	24	25.6	-2.8	1.153	0.4	0.3	0	45.6	40	0	139	126	0	33	33	33
2025	4	23	23	5	24	26.5	-1.6	1.153	0.4	0.3	0	45.2	40.4	0	139	126	0	34	32	33
2025	4	23	23	15	24	26	-2.8	1.153	0.4	0.3	0	45.2	41.3	0	139	128	0	34	32	33
2025	4	23	23	25	24	27.9	-3.3	1.153	0.3	0.2	0	45.6	41.3	0	140	129	0	34	33	33
2025	4	23	23	35	24	26.1	-3.6	1.153	0.5	0.4	0	45.6	40.9	0	140	128	0	34	33	33
2025	4	23	23	45	24	27.3	-3.2	1.154	0.3	0.2	0	45.6	40.9	0	140	128	0	34	33	33
2025	4	23	23	55	24	27.4	-3	1.154	0.3	0.2	0	45.6	40.9	0	140	128	0	34	33	33
2025	4	24	0	5	24	26.4	-3.1	1.154	0.3	0.2	0	45.6	41.3	0	140	129	0	34	33	34
2025	4	24	0	15	24	27.1	-3.5	1.154	0.3	0.2	0	45.6	41.3	0	140	128	0	34	32	33
2025	4	24	0	25	24	26.6	-2.8	1.154	0.5	0.4	0	45.6	41.3	0	140	128	0	34	32	33
2025	4	24	0	35	24	26.2	-2.7	1.154	0.3	0.2	0	45.2	41.7	0	140	129	0	35	32	33
2025	4	24	0	45	24	25.2	-3.9	1.153	0.4	0.3	0	45.6	40.9	0	140	128	0	34	33	33
2025	4	24	0	55	24	25.8	-3.6	1.154	0.3	0.2	0	45.6	41.3	0	140	128	0	34	32	34
2025	4	24	1	5	24	25.9	-2.5	1.154	0.4	0.3	0	45.6	41.3	0	140	128	0	34	32	34
2025	4	24	1	15	24	26.3	-3	1.154	0.5	0.5	0	45.2	40.9	0	139	127	0	34	32	34
2025	4	24	1	25	24	25.3	-2.7	1.154	0.3	0.2	0	45.2	41.3	0	139	128	0	34	32	34
2025	4	24	1	35	24	25.8	-3.1	1.154	0.3	0.2	0	44.7	41.3	0	138	128	0	34	32	34
2025	4	24	1	45	24	24.5	-2	1.154	0.5	0.5	0	45.6	41.3	0	139	129	0	33	33	33
2025	4	24	1	55	24	25.7	-3.1	1.153	0.3	0.2	0	44.7	40.9	0	138	128	0	34	33	34
2025	4	24	2	5	24	26.5	-3.7	1.154	0.3	0.2	0	45.2	40.9	0	138	128	0	33	33	33
2025	4	24	2	15	24	26.3	-4.2	1.154	0.3	0.2	0	45.2	40.9	0	139	128	0	34	33	33
2025	4	24	2	25	24	25.7	-2.3	1.154	0.5	0.4	0	44.7	40.9	0	138	128	0	34	33	33
2025	4	24	2	35	24	25.2	-3.4	1.154	0.5	0.4	0	45.2	41.3	0	139	128	0	34	32	33
2025	4	24	2	45	24	25.3	-2.7	1.154	0.3	0.2	0	45.2	41.3	0	139	128	0	34	32	33
2025	4	24	2	55	24	26.9	-3.3	1.154	0.3	0.2	0	45.2	40.9	0	139	128	0	34	33	33
2025	4	24	3	5	24	26.2	-2.9	1.154	0.3	0.2	0	44.7	41.3	0	138	128	0	34	32	33
2025	4	24	3	15	24	26.5	-3.9	1.154	0.3	0.2	0	44.7	40.9	0	138	128	0	34	33	34
2025	4	24	3	25	24	25.6	-3	1.154	0.5	0.4	0	44.7	40.9	0	138	128	0	34	33	34
2025	4	24	3	35	24	25.5	-3.1	1.154	0.3	0.2	0	45.2	41.3	0	139	129	0	34	33	34
2025	4	24	3	45	24	26.4	-2.8	1.154	0.4	0.3	0	45.6	41.7	0	139	129	0	33	32	34
2025	4	24	3	55	24	26.1	-2.6	1.154	0.5	0.5	0	45.2	42.1	0	139	129	0	34	31	33
2025	4	24	4	5	24	26.2	-2.9	1.154	0.4	0.3	0	45.2	40.9	0	139	129	0	34	34	34
2025	4	24	4	15	24	25.9	-3.6	1.154	0.4	0.3	0	44.7	41.3	0	139	129	0	35	33	34
2025	4	24	4	25	24	26.5	-2.7	1.154	0.5	0.4	0	44.7	41.7	0	138	129	0	34	32	33
2025	4	24	4	35	24	26.5	-3.1	1.154	0.3	0.2	0	44.7	41.3	0	138	128	0	34	32	33
2025	4	24	4	45	24	25.4	-2.7	1.154	0.4	0.3	0	44.7	41.7	0	138	129	0	34	32	33
2025	4	24	4	55	24	26.6	-2.6	1.154	0.4	0.3	0	44.7	41.7	0	138	129	0	34	32	33
2025	4	24	5	5	24	26.1	-2	1.154	0.4	0.3	0	44.7	41.7	0	138	129	0	34	32	33
2025	4	24	5	15	24	25.5	-2.2	1.154	0.4	0.3	0	44.7	41.7	0	139	129	0	35	32	33
2025	4	24	5	25	24	25.9	-3.1	1.154	0.5	0.4	0	45.2	41.3	0	139	129	0	34	33	34
2025	4	24	5	35	24	26.3	-2.6	1.154	0.4	0.3	0	45.2	41.7	0	139	129	0	34	32	33
2025	4	24	5	45	24	26.4	-2.1	1.154	0.3	0.2	0	45.2	41.3	0	139	129	0	34	33	33
2025	4	24	5	55	24	25.3	-3	1.154	0.4	0.3	0	45.2	41.7	0	139	129	0	34	32	33
2025	4	24	6	5	24	23.6	-1.8	1.154	0.4	0.3	0	47.3	40.9	0	144	128	0	34	33	34
2025	4	24	6	15	24	25.8	-2.2	1.153	0.4	0.3	0	46.9	40.9	0	142	128	0	33	33	34
2025	4	24	6	25	24	26.1	-3.5	1.153	0.5	0.4	0	45.6	40.4	0	141	127	0	35	33	33
2025	4	24	6	35	24	25.1	-2.4	1.154	0.3	0.2	0	45.6	40.4	0	140	127	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	24	6	45	24	26.6	-2.2	1.153	0.3	0.2	0	45.6	40.4	0	140	127	0	34	33	34
2025	4	24	6	55	24	25.7	-3.1	1.153	0.3	0.2	0	45.6	40	0	140	126	0	34	33	33
2025	4	24	7	5	24	26.1	-2.5	1.153	0.3	0.2	0	44.7	39.6	0	139	125	0	35	33	33
2025	4	24	7	15	24	25.2	-2.6	1.154	0.3	0.2	0	45.6	40	0	139	126	0	33	33	33
2025	4	24	7	25	24	26.6	-2.8	1.154	0.4	0.3	0	45.2	40.4	0	139	126	0	34	32	33
2025	4	24	7	35	24	26	-3.2	1.153	0.5	0.4	0	45.2	40.4	0	139	126	0	34	32	33
2025	4	24	7	45	24	26.2	-1.8	1.153	0.3	0.2	0	45.2	40.4	0	139	126	0	34	32	34
2025	4	24	7	55	24	27	-3.2	1.153	0.5	0.4	0	45.6	40.9	0	140	127	0	34	32	33
2025	4	24	8	5	24	26.2	-3.1	1.152	0.5	0.4	0	45.2	40.4	0	139	126	0	34	32	33
2025	4	24	8	15	24	26.5	-2.7	1.152	0.5	0.4	0	45.2	40.4	0	139	126	0	34	32	33
2025	4	24	8	25	24	25	-2.8	1.151	0.3	0.2	0	45.6	40.4	0	139	126	0	33	32	33
2025	4	24	8	35	24	27	-3.5	1.151	0.4	0.3	0	44.3	40	0	138	126	0	35	33	33
2025	4	24	8	45	24	26	-2.2	1.151	0.4	0.3	0	45.2	40	0	139	126	0	34	33	34
2025	4	24	8	55	24	26.2	-3.2	1.151	0.3	0.2	0	44.7	40	0	138	126	0	34	33	33
2025	4	24	9	5	24	26.1	-2.3	1.153	0.5	0.4	0	44.7	40.4	0	138	126	0	34	32	33
2025	4	24	9	15	24	26.3	-4	1.151	0.3	0.2	0	44.7	40	0	138	126	0	34	33	34
2025	4	24	9	25	24	25.4	-2.9	1.151	0.3	0.2	0	45.2	40.9	0	139	127	0	34	32	34
2025	4	24	9	35	24	25	-2.8	1.151	0.3	0.2	0	45.2	40.4	0	139	127	0	34	33	33
2025	4	24	9	45	24	26.5	-2.3	1.151	0.5	0.4	0	45.6	41.3	0	140	128	0	34	32	33
2025	4	24	9	55	24	25.8	-3	1.151	0.3	0.2	0	45.2	40.9	0	139	127	0	34	32	33
2025	4	24	10	5	24	26.9	-2.4	1.151	0.4	0.3	0	45.6	40.4	0	139	126	0	33	32	33
2025	4	24	10	15	24	25.9	-2.4	1.151	0.4	0.3	0	45.2	40.9	0	139	127	0	34	32	33
2025	4	24	10	25	24	27	-3.3	1.151	0.3	0.2	0	44.3	40	0	137	126	0	34	33	33
2025	4	24	10	35	24	26.8	-3	1.151	0.3	0.2	0	44.7	40.4	0	138	126	0	34	32	34
2025	4	24	10	45	24	26.2	-2.8	1.151	0.3	0.2	0	44.7	40.4	0	138	126	0	34	32	33
2025	4	24	10	55	24	25.4	-1.9	1.151	0.5	0.4	0	44.7	40.4	0	138	126	0	34	32	33
2025	4	24	11	5	24	26.1	-2.9	1.151	0.3	0.2	0	44.7	40.4	0	138	127	0	34	33	34
2025	4	24	11	15	24	26.4	-3.1	1.151	0.5	0.5	0	45.2	40.9	0	139	127	0	34	32	32
2025	4	24	11	25	24	26.8	-2.2	1.151	0.4	0.3	0	44.7	40	0	138	126	0	34	33	34
2025	4	24	11	35	24	25.9	-3.1	1.151	0.5	0.4	0	44.7	40.4	0	138	126	0	34	32	34
2025	4	24	11	45	24	25.9	-2.4	1.151	0.3	0.2	0	44.7	40.4	0	138	126	0	34	32	33
2025	4	24	11	55	24	24.7	-2.5	1.152	0.3	0.2	0	45.6	40.9	0	139	127	0	33	32	33
2025	4	24	12	5	24	25.8	-4.1	1.152	0.4	0.3	0	45.2	40.4	0	138	126	0	33	32	33
2025	4	24	12	15	24	26.2	-3.3	1.152	0.4	0.3	0	44.7	40.9	0	138	127	0	34	32	34
2025	4	24	12	25	24	26.4	-3.2	1.151	0.3	0.2	0	44.7	40	0	138	126	0	34	33	34
2025	4	24	12	35	24	26.1	-3.2	1.152	0.3	0.2	0	45.2	40	0	138	125	0	33	32	33
2025	4	24	12	45	24	25.8	-2.3	1.152	0.5	0.4	0	45.2	40.4	0	138	126	0	33	32	33
2025	4	24	12	55	24	25.1	-3.1	1.152	0.3	0.2	0	44.7	40.9	0	138	127	0	34	32	33
2025	4	24	13	5	24	25.2	-3.2	1.151	0.3	0.2	0	44.7	40.4	0	138	126	0	34	32	33
2025	4	24	13	15	24	24.1	-2.1	1.151	0.3	0.2	0	45.2	40.4	0	138	126	0	33	32	33
2025	4	24	13	25	24	26.5	-3.5	1.152	0.3	0.2	0	44.7	40	0	137	125	0	33	32	33
2025	4	24	13	35	24	26.3	-3.2	1.151	0.4	0.3	0	44.7	40	0	137	126	0	33	33	33
2025	4	24	13	45	24	25.6	-2.7	1.152	0.4	0.3	0	44.3	40	0	137	126	0	34	33	33
2025	4	24	13	55	24	24.9	-2.5	1.153	0.4	0.3	0	45.2	40.9	0	138	127	0	33	32	33
2025	4	24	14	5	24	25.2	-2.4	1.151	0.3	0.2	0	44.7	40.9	0	138	127	0	34	32	32
2025	4	24	14	15	24	26.2	-3.5	1.152	0.4	0.3	0	44.7	40.4	0	137	126	0	33	32	33
2025	4	24	14	25	24	26.3	-3.6	1.152	0.5	0.4	0	44.3	40.4	0	137	126	0	34	32	33
2025	4	24	14	35	24	25.8	-3.4	1.151	0.5	0.4	0	44.7	40	0	137	126	0	33	33	33

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	4	24	14	45	24	26	-3.1	1.151	0.4	0.3	0	45.2	40.4	0	138	126	0	33	32	33	
2025	4	24	14	55	24	25.6	-2.1	1.152	0.4	0.3	0	45.6	40.9	0	139	127	0	33	32	33	
2025	4	24	15	5	24	25.6	-2.7	1.153	0.4	0.3	0	44.3	40.4	0	137	126	0	34	32	33	
2025	4	24	15	15	24	25.1	-2.3	1.151	0.3	0.2	0	45.2	40.9	0	138	127	0	33	32	33	
2025	4	24	15	25	24	24.9	-1.4	1.149	0.4	0.3	0	45.2	40.9	0	139	127	0	34	32	33	
2025	4	24	15	35	24	24.6	-2.8	1.152	0.5	0.4	0	44.7	40.4	0	138	127	0	34	33	33	
2025	4	24	15	45	24	24.7	-2.4	1.152	0.5	0.4	0	45.2	40.9	0	139	127	0	34	32	33	
2025	4	24	15	55	24	25.6	-3.2	1.151	0.5	0.5	0	45.2	40.9	0	138	127	0	33	32	33	
2025	4	24	16	5	24	24.7	-2.7	1.152	0.4	0.3	0	44.7	40.9	0	138	127	0	34	32	33	
2025	4	24	16	15	24	25.7	-2.5	1.151	0.3	0.2	0	45.2	40.9	0	139	128	0	34	33	33	
2025	4	24	16	25	24	25	-2.3	1.151	0.5	0.4	0	46	41.3	0	141	128	0	34	32	33	
2025	4	24	16	35	24	25.6	-1.8	1.152	0.3	0.2	0	46.4	41.3	0	141	128	0	33	32	33	
2025	4	24	16	45	24	24.1	-2.3	1.151	0.3	0.2	0	46.4	41.7	0	141	129	0	33	32	34	
2025	4	24	16	55	24	24.3	-2.6	1.15	0.4	0.3	0	46.4	41.3	0	141	128	0	33	32	33	
2025	4	24	17	5	24	26.4	-3	1.151	0.4	0.3	0	46	40.9	0	140	127	0	33	32	32	
2025	4	24	17	15	24	23.9	-2.3	1.151	0.5	0.4	0	45.6	40.4	0	140	127	0	34	33	33	
2025	4	24	17	25	24	24.5	-2.4	1.15	0.5	0.4	0	45.6	40.9	0	140	127	0	34	32	33	
2025	4	24	17	35	24	25.4	-2.3	1.15	0.4	0.3	0	45.6	40.9	0	140	127	0	34	32	33	
2025	4	24	17	45	24	25.2	-2.2	1.15	0.3	0.2	0	46	40.9	0	140	127	0	33	32	33	
2025	4	24	17	55	24	25	-2.4	1.151	0.5	0.5	0	45.6	40.9	0	140	127	0	34	32	33	
2025	4	24	18	5	24	25.5	-3.1	1.15	0.3	0.2	0	45.6	40.9	0	140	127	0	34	32	33	
2025	4	24	18	15	24	26.2	-3.6	1.15	0.3	0.2	0	45.6	40.9	0	140	127	0	34	32	33	
2025	4	24	18	25	24	25.5	-3.2	1.151	0.5	0.4	0	46	40.9	0	140	127	0	33	32	33	
2025	4	24	18	35	24	25.6	-1.9	1.151	0.4	0.3	0	45.6	40.9	0	140	127	0	34	32	33	
2025	4	24	18	45	24	24.6	-1.8	1.15	0.3	0.2	0	45.6	40	0	140	126	0	34	33	32	
2025	4	24	18	55	24	25.4	-2	1.151	0.4	0.3	0	46	40.9	0	140	127	0	33	32	33	
2025	4	24	19	5	24	24.9	-2.2	1.15	0.4	0.3	0	45.6	40.9	0	140	127	0	34	32	33	
2025	4	24	19	15	24	25.4	-3	1.15	0.3	0.2	0	45.6	40.9	0	140	127	0	34	32	33	
2025	4	24	19	25	24	23.6	-2.3	1.15	0.4	0.3	0	46.4	40.9	0	141	128	0	33	33	33	
2025	4	24	19	35	24	26.3	-2.8	1.149	0.4	0.3	0	46	41.7	0	141	129	0	34	32	33	
2025	4	24	19	45	24	25.4	-2.3	1.15	0.4	0.3	0	46.9	41.7	0	142	129	0	33	32	34	
2025	4	24	19	55	24	25.2	-3	1.15	0.4	0.3	0	46.9	41.3	0	142	129	0	33	33	33	
2025	4	24	20	5	24	25.3	-2.7	1.149	0.4	0.3	0	46.9	42.1	0	143	131	0	34	33	34	
2025	4	24	20	15	24	26.4	-3.1	1.149	0.4	0.3	0	46.9	42.1	0	143	131	0	34	33	34	
2025	4	24	20	25	24	25.9	-2.2	1.148	0.3	0.2	0	47.3	42.1	0	144	131	0	34	33	34	
2025	4	24	20	35	24	25.7	-3.5	1.149	0.4	0.3	0	47.3	42.1	0	143	130	0	33	32	34	
2025	4	24	20	45	24	25.9	-2.7	1.148	0.4	0.3	0	46.4	42.6	0	143	131	0	35	32	34	
2025	4	24	20	55	24	25.7	-2.3	1.149	0.3	0.2	0	47.3	42.1	0	143	130	0	33	32	33	
2025	4	24	21	5	24	26.1	-2.9	1.148	0.4	0.3	0	46.9	42.1	0	143	130	0	34	32	32	
2025	4	24	21	15	24	24.9	-3.2	1.149	0.4	0.3	0	46.4	42.1	0	142	130	0	34	32	33	
2025	4	24	21	25	24	25.6	-3.2	1.149	0.5	0.4	0	47.3	41.7	0	143	130	0	33	33	34	
2025	4	24	21	35	24	25.4	-2.9	1.148	0.3	0.2	0	46.4	42.1	0	142	130	0	34	32	33	
2025	4	24	21	45	24	25.6	-3.2	1.148	0.3	0.2	0	46.4	42.1	0	142	130	0	34	32	33	
2025	4	24	21	55	24	25.6	-2.8	1.148	0.3	0.2	0	46.4	41.7	0	142	129	0	34	32	33	
2025	4	24	22	5	24	25.7	-2.7	1.148	0.4	0.3	0	46.4	42.1	0	142	130	0	34	32	33	
2025	4	24	22	15	24	26.3	-2.5	1.148	0.4	0.3	0	46	41.7	0	141	129	0	34	32	33	
2025	4	24	22	25	24	25.4	-1.6	1.148	0.3	0.2	0	46.9	41.7	0	142	129	0	33	32	33	
2025	4	24	22	35	24	26	-2	1.148	0.4	0.3	0	47.3	41.7	0	143	130	0	33	33	33	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	24	22	45	24	26.4	-2.7	1.148	0.4	0.3	0	46.9	41.3	0	143	129	0	34	33	33
2025	4	24	22	55	24	24.8	-2.2	1.149	0.3	0.2	0	46.9	40.9	0	143	129	0	34	34	34
2025	4	24	23	5	24	25.4	-2.3	1.148	0.4	0.3	0	46.9	41.7	0	143	129	0	34	32	33
2025	4	24	23	15	24	26	-4.4	1.147	0.3	0.2	0	46.4	41.3	0	142	129	0	34	33	33
2025	4	24	23	25	24	25.6	-2.8	1.148	0.4	0.3	0	46.9	41.7	0	143	129	0	34	32	33
2025	4	24	23	35	24	26.9	-3.1	1.147	0.3	0.2	0	46.4	41.7	0	142	129	0	34	32	34
2025	4	24	23	45	24	25.5	-2.5	1.147	0.3	0.2	0	46.9	41.7	0	142	129	0	33	32	34
2025	4	24	23	55	24	25.8	-3.5	1.147	0.3	0.2	0	46.9	41.7	0	142	129	0	33	32	34
2025	4	25	0	5	24	25.9	-2.1	1.147	0.3	0.2	0	46.9	41.7	0	142	129	0	33	32	34
2025	4	25	0	15	24	26.4	-2.8	1.147	0.5	0.4	0	46	40.9	0	142	128	0	35	33	33
2025	4	25	0	25	24	25.9	-2.8	1.147	0.4	0.3	0	46.4	40.9	0	142	128	0	34	33	33
2025	4	25	0	35	24	25.8	-3.3	1.147	0.3	0.2	0	46.4	41.7	0	142	129	0	34	32	33
2025	4	25	0	45	24	25.9	-2.2	1.147	0.3	0.2	0	46	40.9	0	141	128	0	34	33	33
2025	4	25	0	55	24	26	-2.6	1.147	0.5	0.5	0	46.4	41.3	0	141	128	0	33	32	34
2025	4	25	1	5	24	24.6	-2	1.147	0.4	0.3	0	46.9	41.7	0	142	129	0	33	32	33
2025	4	25	1	15	24	25.4	-2.5	1.147	0.3	0.2	0	46	41.3	0	141	129	0	34	33	33
2025	4	25	1	25	24	25.1	-3.1	1.147	0.3	0.2	0	46	41.7	0	141	129	0	34	32	33
2025	4	25	1	35	24	25.3	-2.8	1.147	0.3	0.2	0	46.4	41.7	0	142	129	0	34	32	34
2025	4	25	1	45	24	26.7	-3.1	1.147	0.5	0.4	0	46	40.9	0	141	128	0	34	33	32
2025	4	25	1	55	24	25.2	-2.7	1.147	0.3	0.2	0	46	40.9	0	141	128	0	34	33	34
2025	4	25	2	5	24	25.4	-2.4	1.146	0.3	0.2	0	46	40.9	0	141	128	0	34	33	34
2025	4	25	2	15	24	25.4	-3.1	1.146	0.4	0.3	0	46	41.3	0	141	128	0	34	32	33
2025	4	25	2	25	24	25	-2.2	1.147	0.4	0.3	0	46	41.3	0	141	128	0	34	32	34
2025	4	25	2	35	24	25.2	-3.7	1.146	0.4	0.3	0	46	41.3	0	140	128	0	33	32	33
2025	4	25	2	45	24	25.5	-2.7	1.146	0.3	0.2	0	46	41.3	0	141	128	0	34	32	33
2025	4	25	2	55	24	25	-2.8	1.146	0.3	0.2	0	46.4	41.3	0	141	128	0	33	32	33
2025	4	25	3	5	24	27.5	-1.6	1.147	0.5	0.4	0	46	41.7	0	141	129	0	34	32	33
2025	4	25	3	15	24	26.2	-3.7	1.147	0.3	0.2	0	46	41.7	0	141	129	0	34	32	33
2025	4	25	3	25	24	26.1	-2	1.147	0.4	0.3	0	46.4	41.3	0	142	129	0	34	33	33
2025	4	25	3	35	24	25.3	-2.8	1.147	0.3	0.2	0	46.9	41.7	0	142	129	0	33	32	33
2025	4	25	3	45	24	26.2	-2.4	1.147	0.3	0.2	0	46	41.7	0	141	128	0	34	31	34
2025	4	25	3	55	24	26.1	-3.5	1.146	0.4	0.3	0	46	41.7	0	141	129	0	34	32	34
2025	4	25	4	5	24	25.1	-3.3	1.146	0.4	0.3	0	45.6	40.9	0	140	128	0	34	33	34
2025	4	25	4	15	24	25.9	-2.8	1.146	0.4	0.3	0	46.4	42.1	0	142	130	0	34	32	33
2025	4	25	4	25	24	25.9	-2.6	1.146	0.4	0.3	0	46	41.3	0	141	128	0	34	32	33
2025	4	25	4	35	24	25.4	-3	1.146	0.4	0.3	0	46	41.7	0	141	129	0	34	32	33
2025	4	25	4	45	24	25.4	-3.1	1.146	0.3	0.2	0	46	41.7	0	141	129	0	34	32	33
2025	4	25	4	55	24	26.1	-2.8	1.147	0.4	0.3	0	45.6	42.1	0	141	129	0	35	31	33
2025	4	25	5	5	24	25.1	-1.8	1.147	0.3	0.2	0	46	41.3	0	141	129	0	34	33	34
2025	4	25	5	15	24	25.4	-2.7	1.146	0.4	0.3	0	46	41.3	0	141	129	0	34	33	33
2025	4	25	5	25	24	25.9	-3.4	1.146	0.3	0.2	0	45.6	41.3	0	140	129	0	34	33	33
2025	4	25	5	35	24	25.6	-3.3	1.146	0.5	0.5	0	45.6	41.3	0	140	129	0	34	33	34
2025	4	25	5	45	24	25.2	-1.9	1.146	0.5	0.4	0	46	41.3	0	141	129	0	34	33	33
2025	4	25	5	55	24	25.4	-2.4	1.146	0.3	0.2	0	45.6	41.7	0	140	129	0	34	32	34
2025	4	25	6	5	24	24.8	-2.3	1.146	0.4	0.3	0	45.6	40.9	0	140	128	0	34	33	34
2025	4	25	6	15	24	25.9	-2.5	1.146	0.4	0.3	0	45.6	40.9	0	140	128	0	34	33	33
2025	4	25	6	25	24	25.4	-2.9	1.146	0.3	0.2	0	45.2	40.9	0	139	128	0	34	33	34
2025	4	25	6	35	24	26	-2.7	1.147	0.3	0.2	0	45.2	40.4	0	139	127	0	34	33	33

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	4	25	6	45	24	25	-2.6	1.147	0.3	0.2	0	45.2	40.9	0	139	127	0	34	32	33	
2025	4	25	6	55	24	24.9	-1.8	1.147	0.5	0.4	0	45.2	40.4	0	139	127	0	34	33	33	
2025	4	25	7	5	24	25.6	-3	1.146	0.3	0.2	0	44.7	40.4	0	138	127	0	34	33	34	
2025	4	25	7	15	24	25.5	-3.7	1.146	0.4	0.3	0	44.7	40.9	0	138	127	0	34	32	34	
2025	4	25	7	25	24	25.5	-2.3	1.146	0.3	0.2	0	44.7	39.6	0	138	126	0	34	34	33	
2025	4	25	7	35	24	25.4	-3.7	1.147	0.4	0.3	0	44.7	40	0	138	126	0	34	33	33	
2025	4	25	7	45	24	25.4	-3.4	1.146	0.3	0.2	0	44.7	40.9	0	138	127	0	34	32	33	
2025	4	25	7	55	24	24.8	-3.8	1.147	0.5	0.4	0	45.2	40.9	0	139	128	0	34	33	33	
2025	4	25	8	5	24	25.2	-2.1	1.147	0.5	0.4	0	45.2	40.9	0	138	127	0	33	32	33	
2025	4	25	8	15	24	26.7	-2.1	1.147	0.3	0.2	0	44.3	40	0	137	126	0	34	33	33	
2025	4	25	8	25	24	26	-2.6	1.147	0.3	0.2	0	44.3	40.4	0	137	126	0	34	32	34	
2025	4	25	8	35	24	26	-2.8	1.147	0.4	0.3	0	44.3	40	0	137	126	0	34	33	33	
2025	4	25	8	45	24	25.1	-2.3	1.147	0.4	0.3	0	44.7	40.4	0	138	127	0	34	33	34	
2025	4	25	8	55	24	26.1	-3	1.147	0.4	0.3	0	44.7	40.9	0	138	127	0	34	32	34	
2025	4	25	9	5	24	25.6	-3.6	1.147	0.4	0.3	0	44.3	40.4	0	137	126	0	34	32	34	
2025	4	25	9	15	24	25.2	-2.4	1.147	0.3	0.2	0	44.3	40.4	0	137	126	0	34	32	34	
2025	4	25	9	25	24	25.6	-2.7	1.147	0.3	0.2	0	45.2	40.9	0	138	127	0	33	32	33	
2025	4	25	9	35	24	24.7	-2.8	1.147	0.4	0.3	0	44.7	40.9	0	138	127	0	34	32	34	
2025	4	25	9	45	24	25.2	-3.2	1.147	0.3	0.2	0	45.2	40.4	0	139	127	0	34	33	34	
2025	4	25	9	55	24	25.9	-2.6	1.147	0.3	0.2	0	44.7	40.9	0	138	127	0	34	32	33	
2025	4	25	10	5	24	25.6	-3.2	1.147	0.3	0.2	0	44.7	40	0	138	126	0	34	33	33	
2025	4	25	10	15	24	25.2	-1.5	1.146	0.5	0.4	0	44.7	40.9	0	138	127	0	34	32	33	
2025	4	25	10	25	24	25.1	-2.7	1.147	0.4	0.3	0	45.2	40.4	0	138	127	0	33	33	33	
2025	4	25	10	35	24	24.9	-2.7	1.147	0.4	0.3	0	46	40.9	0	141	127	0	34	32	33	
2025	4	25	10	45	24	25.2	-2.2	1.148	0.3	0.2	0	46.4	40.4	0	141	127	0	33	33	33	
2025	4	25	10	55	24	24.9	-1.8	1.148	0.3	0.2	0	46	40.9	0	141	128	0	34	33	33	
2025	4	25	11	5	24	25.4	-2.7	1.148	0.5	0.4	0	46	40.9	0	141	127	0	34	32	34	
2025	4	25	11	15	24	25.5	-2.8	1.148	0.3	0.2	0	46.4	40.9	0	141	127	0	33	32	33	
2025	4	25	11	25	24	26	-1.8	1.147	0.3	0.2	0	45.6	40.4	0	140	127	0	34	33	33	
2025	4	25	11	35	24	25.5	-1.5	1.148	0.4	0.3	0	45.6	40.4	0	140	126	0	34	32	33	
2025	4	25	11	45	24	25.1	-3.2	1.147	0.4	0.3	0	45.2	40.4	0	139	126	0	34	32	33	
2025	4	25	11	55	24	25.5	-1.5	1.148	0.4	0.3	0	46	40	0	140	126	0	33	33	33	
2025	4	25	12	5	24	25.5	-2.3	1.149	0.4	0.3	0	45.6	40	0	140	126	0	34	33	33	
2025	4	25	12	15	24	24.2	-2.5	1.148	0.4	0.3	0	46	40.4	0	140	126	0	33	32	33	
2025	4	25	12	25	24	24.9	-2.8	1.148	0.4	0.3	0	45.2	40.4	0	139	126	0	34	32	33	
2025	4	25	12	35	24	25.4	-2.4	1.148	0.4	0.3	0	45.6	40.4	0	140	126	0	34	32	33	
2025	4	25	12	45	24	24.9	-2.3	1.149	0.4	0.3	0	45.2	40	0	139	126	0	34	33	34	
2025	4	25	12	55	24	24.6	-2.7	1.148	0.4	0.3	0	45.6	40.4	0	140	126	0	34	32	33	
2025	4	25	13	5	24	24.4	-2.2	1.148	0.3	0.2	0	45.6	40.4	0	140	126	0	34	32	33	
2025	4	25	13	15	24	25.1	-2.4	1.149	0.3	0.2	0	45.2	40	0	139	126	0	34	33	32	
2025	4	25	13	25	24	24.2	-2.3	1.148	0.3	0.2	0	45.2	40.4	0	139	126	0	34	32	33	
2025	4	25	13	35	24	24.6	-2.6	1.149	0.3	0.2	0	46	40.9	0	140	127	0	33	32	33	
2025	4	25	13	45	24	25.3	-2.6	1.148	0.4	0.3	0	45.6	40.4	0	140	126	0	34	32	34	
2025	4	25	13	55	24	25	-2.7	1.147	0.4	0.3	0	45.6	40.4	0	140	126	0	34	32	33	
2025	4	25	14	5	24	25.5	-2.8	1.147	0.3	0.2	0	46	40.4	0	140	126	0	33	32	34	
2025	4	25	14	15	24	25.6	-2.6	1.146	0.3	0.2	0	45.6	40.4	0	140	127	0	34	33	33	
2025	4	25	14	25	24	24.1	-2.4	1.149	0.4	0.3	0	45.6	40.9	0	140	127	0	34	32	34	
2025	4	25	14	35	24	24.3	-2.8	1.148	0.5	0.4	0	46	41.3	0	141	128	0	34	32	33	

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	4	25	14	45	24	24.7	-2.5	1.148	0.3	0.2	0	46.4	41.3	0	141	128	0	33	32	33	
2025	4	25	14	55	24	25.5	-3.2	1.148	0.3	0.2	0	46	40.9	0	140	127	0	33	32	33	
2025	4	25	15	5	24	24.6	-3	1.147	0.3	0.2	0	45.6	40.9	0	140	127	0	34	32	33	
2025	4	25	15	15	24	24.8	-1.9	1.147	0.3	0.2	0	46	41.3	0	140	128	0	33	32	32	
2025	4	25	15	25	24	25.6	-3.4	1.148	0.3	0.2	0	45.6	40.4	0	140	127	0	34	33	33	
2025	4	25	15	35	24	25.7	-2	1.147	0.3	0.2	0	46	40.9	0	141	128	0	34	33	33	
2025	4	25	15	45	24	25	-1.4	1.148	0.4	0.3	0	45.6	40.9	0	140	127	0	34	32	33	
2025	4	25	15	55	24	24.7	-2.2	1.148	0.4	0.3	0	45.6	40.4	0	140	127	0	34	33	33	
2025	4	25	16	5	24	25.2	-1.8	1.147	0.3	0.2	0	45.6	40.9	0	139	127	0	33	32	33	
2025	4	25	16	15	24	25.1	-2.9	1.146	0.3	0.2	0	46.4	41.3	0	141	128	0	33	32	33	
2025	4	25	16	25	24	25	-1.3	1.146	0.3	0.2	0	46.4	41.3	0	141	128	0	33	32	33	
2025	4	25	16	35	24	25.2	-2.8	1.147	0.4	0.3	0	45.6	41.3	0	140	128	0	34	32	33	
2025	4	25	16	45	24	24	-2.4	1.147	0.3	0.2	0	46	40.9	0	141	128	0	34	33	34	
2025	4	25	16	55	24	26.7	-3	1.146	0.4	0.3	0	46	41.3	0	141	128	0	34	32	33	
2025	4	25	17	5	24	24.9	-3.2	1.148	0.4	0.3	0	46	40.9	0	140	127	0	33	32	33	
2025	4	25	17	15	24	24.5	-1.7	1.15	0.4	0.3	0	45.6	40.4	0	140	127	0	34	33	32	
2025	4	25	17	25	24	24.3	-2.4	1.148	0.4	0.3	0	46	40.4	0	140	127	0	33	33	32	
2025	4	25	17	35	24	25.7	-3	1.146	0.5	0.4	0	45.2	40.4	0	139	126	0	34	32	33	
2025	4	25	17	45	24	25.3	-3.2	1.148	0.3	0.2	0	44.7	40.4	0	138	126	0	34	32	33	
2025	4	25	17	55	24	24.8	-3.6	1.147	0.5	0.4	0	45.2	40.4	0	139	126	0	34	32	33	
2025	4	25	18	5	24	24.6	-2.7	1.146	0.4	0.3	0	45.6	40.4	0	139	126	0	33	32	33	
2025	4	25	18	15	24	24.5	-3	1.147	0.3	0.2	0	45.2	40.4	0	139	126	0	34	32	33	
2025	4	25	18	25	24	25.6	-2.9	1.146	0.3	0.2	0	45.2	40.4	0	139	126	0	34	32	33	
2025	4	25	18	35	24	24.9	-2.9	1.147	0.3	0.2	0	45.2	40	0	139	126	0	34	33	33	
2025	4	25	18	45	24	24.6	-2.3	1.146	0.3	0.2	0	45.6	40.9	0	140	127	0	34	32	34	
2025	4	25	18	55	24	25.7	-3.6	1.147	0.3	0.2	0	45.2	40.9	0	139	127	0	34	32	33	
2025	4	25	19	5	24	25	-2.3	1.147	0.4	0.3	0	45.6	40.4	0	140	127	0	34	33	33	
2025	4	25	19	15	24	25.6	-3.2	1.147	0.4	0.3	0	45.6	40.4	0	139	126	0	33	32	33	
2025	4	25	19	25	24	24.3	-2.2	1.146	0.3	0.2	0	45.6	40.9	0	140	127	0	34	32	33	
2025	4	25	19	35	24	25.1	-2.1	1.147	0.4	0.3	0	46	41.3	0	140	128	0	33	32	32	
2025	4	25	19	45	24	25.6	-2.8	1.147	0.3	0.2	0	46	41.3	0	141	128	0	34	32	33	
2025	4	25	19	55	24	24.1	-2.9	1.145	0.3	0.2	0	46.9	41.3	0	142	129	0	33	33	33	
2025	4	25	20	5	24	25.7	-1.6	1.147	0.5	0.5	0	46	41.3	0	141	128	0	34	32	33	
2025	4	25	20	15	24	25.1	-3	1.146	0.4	0.3	0	46.4	42.1	0	142	130	0	34	32	33	
2025	4	25	20	25	24	25.1	-2.5	1.148	0.5	0.4	0	46.4	41.7	0	142	129	0	34	32	34	
2025	4	25	20	35	24	24.9	-1.9	1.147	0.4	0.3	0	46.4	41.7	0	142	130	0	34	33	33	
2025	4	25	20	45	24	24.8	-2	1.147	0.4	0.3	0	46.4	41.7	0	142	129	0	34	32	34	
2025	4	25	20	55	24	25.1	-1.8	1.147	0.3	0.2	0	46.4	41.7	0	142	130	0	34	33	34	
2025	4	25	21	5	24	25.8	-3	1.146	0.3	0.2	0	46	40.9	0	141	128	0	34	33	33	
2025	4	25	21	15	24	25	-3.4	1.146	0.3	0.2	0	46.4	41.3	0	142	129	0	34	33	34	
2025	4	25	21	25	24	24.2	-2.6	1.146	0.4	0.3	0	46	41.3	0	142	129	0	35	33	34	
2025	4	25	21	35	24	25.5	-3.4	1.147	0.3	0.2	0	46.4	41.3	0	142	128	0	34	32	34	
2025	4	25	21	45	24	25	-2.8	1.146	0.3	0.2	0	46.9	40.9	0	142	128	0	33	33	34	
2025	4	25	21	55	24	25	-2.4	1.146	0.5	0.4	0	46.4	40.4	0	142	127	0	34	33	33	
2025	4	25	22	5	24	25	-2.2	1.145	0.4	0.3	0	46.4	41.3	0	142	128	0	34	32	34	
2025	4	25	22	15	24	25.5	-2.9	1.147	0.3	0.2	0	46.4	41.3	0	142	128	0	34	32	33	
2025	4	25	22	25	24	25.7	-2.7	1.146	0.3	0.2	0	46	40.4	0	141	127	0	34	33	33	
2025	4	25	22	35	24	25.1	-3.3	1.146	0.5	0.4	0	46	40.9	0	141	128	0	34	33	33	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	25	22	45	24	25.3	-2.7	1.146	0.3	0.2	0	46	40.4	0	141	127	0	34	33	34
2025	4	25	22	55	24	24.1	-3.5	1.145	0.3	0.2	0	46	40.9	0	140	127	0	33	32	33
2025	4	25	23	5	24	25.7	-2.3	1.144	0.3	0.2	0	46	40.4	0	141	127	0	34	33	34
2025	4	25	23	15	24	26.3	-3.4	1.145	0.3	0.2	0	46	40.4	0	141	127	0	34	33	33
2025	4	25	23	25	24	26.7	-1.8	1.145	0.4	0.3	0	46	40.9	0	141	127	0	34	32	34
2025	4	25	23	35	24	26.1	-3.1	1.145	0.4	0.3	0	46	40.4	0	141	127	0	34	33	33
2025	4	25	23	45	24	24.4	-2.1	1.145	0.3	0.2	0	46	41.3	0	142	128	0	35	32	33
2025	4	25	23	55	24	25.3	-2.7	1.146	0.4	0.3	0	46.4	40.9	0	141	128	0	33	33	33
2025	4	26	0	5	24	25.3	-2.4	1.145	0.4	0.3	0	46.4	40.4	0	141	127	0	33	33	33
2025	4	26	0	15	24	26.1	-2.6	1.145	0.3	0.2	0	45.6	40.4	0	140	127	0	34	33	34
2025	4	26	0	25	24	24.8	-2.5	1.145	0.4	0.3	0	45.6	41.3	0	141	128	0	35	32	33
2025	4	26	0	35	24	26.1	-2.1	1.145	0.4	0.3	0	46	40.4	0	141	127	0	34	33	33
2025	4	26	0	45	24	25.7	-3.8	1.145	0.4	0.3	0	46	40.9	0	141	128	0	34	33	33
2025	4	26	0	55	24	25.7	-3.8	1.145	0.4	0.3	0	46	40.9	0	141	127	0	34	32	33
2025	4	26	1	5	24	23.9	-2.5	1.145	0.3	0.2	0	46	40.4	0	141	127	0	34	33	34
2025	4	26	1	15	24	26.2	-2.6	1.145	0.4	0.3	0	45.6	40.4	0	140	127	0	34	33	33
2025	4	26	1	25	24	26.2	-3	1.144	0.5	0.4	0	45.6	40.9	0	140	127	0	34	32	34
2025	4	26	1	35	24	25.9	-3.3	1.144	0.5	0.4	0	45.6	40.4	0	140	127	0	34	33	33
2025	4	26	1	45	24	25.7	-3	1.144	0.3	0.2	0	45.6	40.4	0	140	126	0	34	32	34
2025	4	26	1	55	24	24.2	-2.1	1.145	0.4	0.3	0	45.6	40.4	0	140	127	0	34	33	34
2025	4	26	2	5	24	25.6	-2.5	1.144	0.3	0.2	0	45.6	40.4	0	140	127	0	34	33	33
2025	4	26	2	15	24	26.8	-3	1.144	0.4	0.3	0	45.2	40	0	139	126	0	34	33	34
2025	4	26	2	25	24	24.9	-3.3	1.144	0.4	0.3	0	45.6	40.4	0	140	126	0	34	32	33
2025	4	26	2	35	24	26.1	-3.5	1.144	0.4	0.3	0	45.6	40.4	0	140	127	0	34	33	33
2025	4	26	2	45	24	26	-2.6	1.144	0.3	0.2	0	46	40.4	0	140	127	0	33	33	34
2025	4	26	2	55	24	25.5	-3.4	1.145	0.4	0.3	0	45.6	40.4	0	140	127	0	34	33	34
2025	4	26	3	5	24	26.7	-3	1.144	0.4	0.3	0	45.6	40.4	0	140	127	0	34	33	34
2025	4	26	3	15	24	26	-2.4	1.144	0.3	0.2	0	45.6	40.9	0	140	127	0	34	32	34
2025	4	26	3	25	24	25.1	-3.5	1.144	0.3	0.2	0	45.2	40.9	0	140	127	0	35	32	34
2025	4	26	3	35	24	25.3	-2.9	1.144	0.4	0.3	0	45.6	40.9	0	140	127	0	34	32	34
2025	4	26	3	45	24	25.1	-2.8	1.144	0.5	0.4	0	45.6	40.4	0	140	127	0	34	33	34
2025	4	26	3	55	24	25.7	-2.5	1.145	0.4	0.3	0	45.6	40.4	0	140	127	0	34	33	34
2025	4	26	4	5	24	25.3	-2.6	1.145	0.4	0.3	0	45.2	39.6	0	139	126	0	34	34	34
2025	4	26	4	15	24	26.2	-2.3	1.144	0.3	0.2	0	45.6	40.9	0	140	127	0	34	32	34
2025	4	26	4	25	24	26	-3.9	1.144	0.3	0.2	0	45.6	40.4	0	140	127	0	34	33	35
2025	4	26	4	35	24	26	-3.1	1.145	0.3	0.2	0	45.2	40.9	0	140	127	0	35	32	34
2025	4	26	4	45	24	25.8	-3.1	1.145	0.5	0.5	0	45.2	40.9	0	139	127	0	34	32	34
2025	4	26	4	55	24	25.1	-2.7	1.145	0.4	0.3	0	45.6	40.4	0	140	127	0	34	33	33
2025	4	26	5	5	24	25.8	-3.1	1.145	0.4	0.3	0	45.2	40.9	0	139	127	0	34	32	33
2025	4	26	5	15	24	25.2	-2.1	1.145	0.4	0.3	0	45.6	40.9	0	140	127	0	34	32	34
2025	4	26	5	25	24	25.3	-3.3	1.145	0.3	0.2	0	45.2	40.9	0	139	127	0	34	32	34
2025	4	26	5	35	24	25.2	-2.7	1.144	0.3	0.2	0	45.6	40.9	0	140	127	0	34	32	34
2025	4	26	5	45	24	26.1	-2.6	1.145	0.4	0.3	0	45.2	40	0	139	126	0	34	33	33
2025	4	26	5	55	24	25.8	-2.7	1.145	0.4	0.3	0	45.2	40.4	0	139	127	0	34	33	34
2025	4	26	6	5	24	25.2	-2.4	1.145	0.3	0.2	0	44.7	40.4	0	139	127	0	35	33	34
2025	4	26	6	15	24	25.3	-3.1	1.145	0.4	0.3	0	45.2	40	0	139	126	0	34	33	34
2025	4	26	6	25	24	25.9	-2.5	1.145	0.4	0.3	0	44.7	39.6	0	138	126	0	34	34	33
2025	4	26	6	35	24	25.8	-2.4	1.145	0.3	0.2	0	44.7	39.6	0	138	125	0	34	33	34

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	4	26	6	45	24	25.9	-3	1.146	0.3	0.2	0	44.3	39.6	0	137	125	0	34	33	33	
2025	4	26	6	55	24	24.4	-2	1.145	0.5	0.4	0	44.7	40	0	138	125	0	34	32	33	
2025	4	26	7	5	24	25.6	-3.6	1.145	0.5	0.4	0	43.9	39.1	0	137	124	0	35	33	33	
2025	4	26	7	15	24	26.7	-2.6	1.145	0.3	0.2	0	44.3	39.1	0	137	124	0	34	33	34	
2025	4	26	7	25	24	27	-2.9	1.145	0.4	0.3	0	43.9	39.6	0	136	124	0	34	32	32	
2025	4	26	7	35	24	25.7	-3.3	1.145	0.3	0.2	0	44.3	39.6	0	137	124	0	34	32	34	
2025	4	26	7	45	24	25.6	-2.2	1.145	0.3	0.2	0	43.9	38.7	0	137	124	0	35	34	34	
2025	4	26	7	55	24	26	-2.6	1.145	0.5	0.4	0	43.9	39.1	0	137	124	0	35	33	34	
2025	4	26	8	5	24	24.9	-2.5	1.146	0.4	0.3	0	43.9	39.6	0	137	124	0	35	32	34	
2025	4	26	8	15	24	25.5	-2.9	1.146	0.3	0.2	0	44.3	40	0	137	125	0	34	32	33	
2025	4	26	8	25	24	24.8	-3.2	1.146	0.4	0.3	0	44.3	39.6	0	137	124	0	34	32	34	
2025	4	26	8	35	24	25.3	-3.5	1.146	0.4	0.3	0	44.3	39.1	0	137	124	0	34	33	33	
2025	4	26	8	45	24	26.2	-3.1	1.146	0.4	0.3	0	44.3	40	0	137	125	0	34	32	34	
2025	4	26	8	55	24	24.7	-3.7	1.146	0.5	0.4	0	44.7	40	0	137	125	0	33	32	33	
2025	4	26	9	5	24	24	-2.2	1.146	0.5	0.4	0	43.9	39.6	0	136	125	0	34	33	34	
2025	4	26	9	15	24	24.4	-2.3	1.146	0.5	0.4	0	44.3	39.6	0	137	125	0	34	33	34	
2025	4	26	9	25	24	25.1	-2.2	1.147	0.3	0.2	0	44.3	40	0	137	125	0	34	32	33	
2025	4	26	9	35	24	25.8	-3.3	1.146	0.5	0.4	0	43.9	39.1	0	136	124	0	34	33	34	
2025	4	26	9	45	24	24.7	-3.6	1.147	0.3	0.2	0	43.9	39.6	0	136	125	0	34	33	33	
2025	4	26	9	55	24	24.9	-2.5	1.148	0.5	0.4	0	43.9	40	0	137	126	0	35	33	33	
2025	4	26	10	5	24	26	-3.4	1.148	0.4	0.3	0	44.3	39.6	0	137	125	0	34	33	34	
2025	4	26	10	15	24	25.3	-1.9	1.148	0.4	0.3	0	44.7	40.4	0	138	126	0	34	32	34	
2025	4	26	10	25	24	24.4	-3.7	1.146	0.5	0.5	0	44.7	40	0	138	126	0	34	33	33	
2025	4	26	10	35	24	25.2	-3.1	1.148	0.3	0.2	0	44.7	39.6	0	138	125	0	34	33	33	
2025	4	26	10	45	24	26	-2.6	1.148	0.4	0.3	0	44.7	39.6	0	138	126	0	34	34	33	
2025	4	26	10	55	24	24.9	-3.4	1.148	0.3	0.2	0	43.9	38.3	0	136	122	0	34	33	34	
2025	4	26	11	5	24	25.3	-2.8	1.149	0.5	0.4	0	43.4	38.7	0	135	123	0	34	33	32	
2025	4	26	11	15	24	24.5	-2.9	1.147	0.3	0.2	0	43.4	38.7	0	135	123	0	34	33	34	
2025	4	26	11	25	24	25	-2.4	1.148	0.4	0.3	0	43	38.7	0	134	123	0	34	33	33	
2025	4	26	11	35	24	24.3	-3.2	1.15	0.4	0.3	0	43.4	39.1	0	134	123	0	33	32	34	
2025	4	26	11	45	24	25.2	-3.6	1.148	0.3	0.2	0	43	38.7	0	134	123	0	34	33	33	
2025	4	26	11	55	24	24.7	-1.4	1.147	0.4	0.3	0	43.4	39.1	0	135	123	0	34	32	33	
2025	4	26	12	5	24	24.4	-2.4	1.147	0.3	0.2	0	43	38.3	0	134	122	0	34	33	33	
2025	4	26	12	15	24	25.6	-2.8	1.149	0.3	0.2	0	43.4	38.7	0	135	123	0	34	33	34	
2025	4	26	12	25	24	25.4	-3.8	1.147	0.5	0.4	0	42.6	38.3	0	133	122	0	34	33	34	
2025	4	26	12	35	24	24.8	-2.8	1.149	0.3	0.2	0	43	38.7	0	134	123	0	34	33	34	
2025	4	26	12	45	24	25.4	-3.6	1.148	0.4	0.3	0	43	38.7	0	134	123	0	34	33	34	
2025	4	26	12	55	24	24.3	-2.5	1.148	0.4	0.3	0	43.4	39.6	0	135	124	0	34	32	33	
2025	4	26	13	5	24	25.5	-3.4	1.148	0.3	0.2	0	43.4	39.6	0	135	125	0	34	33	34	
2025	4	26	13	15	24	24.5	-2.6	1.149	0.5	0.4	0	43.9	39.6	0	136	125	0	34	33	33	
2025	4	26	13	25	24	24.5	-3	1.147	0.4	0.3	0	44.3	40.4	0	137	126	0	34	32	34	
2025	4	26	13	35	24	24	-2.7	1.148	0.3	0.2	0	44.3	39.6	0	137	125	0	34	33	34	
2025	4	26	13	45	24	24.5	-2.8	1.15	0.5	0.4	0	43.9	39.6	0	136	126	0	34	34	33	
2025	4	26	13	55	24	24.9	-2.3	1.151	0.4	0.3	0	43.9	40	0	136	125	0	34	32	34	
2025	4	26	14	5	24	25.4	-3.1	1.149	0.4	0.3	0	43.9	40	0	136	125	0	34	32	33	
2025	4	26	14	15	24	24.5	-3.6	1.148	0.3	0.2	0	43.9	39.6	0	136	125	0	34	33	33	
2025	4	26	14	25	24	25.4	-2.6	1.149	0.4	0.3	0	43.9	39.6	0	136	125	0	34	33	34	
2025	4	26	14	35	24	25.9	-2.5	1.148	0.4	0.3	0	44.3	39.6	0	136	125	0	33	33	34	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	26	14	45	24	24	-3.1	1.149	0.3	0.2	0	43.4	39.1	0	135	124	0	34	33	34
2025	4	26	14	55	24	25.1	-3	1.149	0.4	0.3	0	43	39.1	0	134	124	0	34	33	34
2025	4	26	15	5	24	24.8	-3.5	1.149	0.3	0.2	0	43.4	39.6	0	135	125	0	34	33	33
2025	4	26	15	15	24	25.3	-2.5	1.151	0.3	0.2	0	44.3	40.4	0	137	127	0	34	33	33
2025	4	26	15	25	24	25.6	-3	1.15	0.4	0.3	0	43.9	40.9	0	137	127	0	35	32	33
2025	4	26	15	35	24	24.8	-2.2	1.149	0.3	0.2	0	44.7	40	0	137	126	0	33	33	33
2025	4	26	15	45	24	25.3	-3.1	1.149	0.4	0.3	0	44.3	40.4	0	137	126	0	34	32	34
2025	4	26	15	55	24	25.2	-2.6	1.149	0.3	0.2	0	43.9	40	0	136	126	0	34	33	34
2025	4	26	16	5	24	24.3	-4.1	1.149	0.4	0.3	0	43	39.1	0	134	124	0	34	33	34
2025	4	26	16	15	24	25.2	-2.9	1.149	0.4	0.3	0	43	38.7	0	134	123	0	34	33	34
2025	4	26	16	25	24	24	-3.4	1.15	0.4	0.3	0	43	39.1	0	134	123	0	34	32	34
2025	4	26	16	35	24	24.8	-2.6	1.149	0.3	0.2	0	43	39.1	0	134	123	0	34	32	33
2025	4	26	16	45	24	24.9	-3.1	1.15	0.4	0.3	0	42.6	38.3	0	133	122	0	34	33	33
2025	4	26	16	55	24	24.4	-2.9	1.149	0.3	0.2	0	43	38.7	0	134	123	0	34	33	34
2025	4	26	17	5	24	26.6	-2.9	1.148	0.3	0.2	0	42.6	38.3	0	133	122	0	34	33	33
2025	4	26	17	15	24	25.2	-2.9	1.148	0.3	0.2	0	42.6	38.3	0	133	122	0	34	33	33
2025	4	26	17	25	24	25.5	-2.7	1.148	0.4	0.3	0	42.1	37.8	0	132	121	0	34	33	33
2025	4	26	17	35	24	24.8	-3	1.149	0.5	0.4	0	41.7	37.8	0	132	121	0	35	33	34
2025	4	26	17	45	24	25.7	-2.5	1.148	0.3	0.2	0	42.1	38.3	0	132	122	0	34	33	33
2025	4	26	17	55	24	25	-2.6	1.148	0.4	0.3	0	42.1	38.3	0	132	121	0	34	32	33
2025	4	26	18	5	24	25.6	-2.6	1.148	0.3	0.2	0	42.1	37.8	0	132	121	0	34	33	34
2025	4	26	18	15	24	24.7	-3.5	1.149	0.4	0.3	0	42.1	38.3	0	132	121	0	34	32	34
2025	4	26	18	25	24	25.6	-1.7	1.149	0.3	0.2	0	42.1	37.8	0	132	121	0	34	33	34
2025	4	26	18	35	24	26	-2.9	1.148	0.3	0.2	0	42.1	38.3	0	132	121	0	34	32	34
2025	4	26	18	45	24	26.5	-2.4	1.149	0.4	0.3	0	41.7	38.3	0	132	121	0	35	32	34
2025	4	26	18	55	24	26.1	-3.7	1.15	0.4	0.3	0	44.3	38.3	0	137	121	0	34	32	34
2025	4	26	19	5	24	25.8	-3.1	1.15	0.4	0.3	0	44.3	37.4	0	137	120	0	34	33	33
2025	4	26	19	15	24	25.5	-3	1.15	0.5	0.4	0	44.3	37.8	0	137	121	0	34	33	33
2025	4	26	19	25	24	25.5	-3.4	1.15	0.3	0.2	0	44.7	38.3	0	138	122	0	34	33	34
2025	4	26	19	35	24	27.2	-3.1	1.151	0.4	0.3	0	44.7	38.3	0	138	122	0	34	33	34
2025	4	26	19	45	24	25.2	-2.7	1.15	0.4	0.3	0	45.6	38.3	0	139	122	0	33	33	34
2025	4	26	19	55	24	25.5	-3.5	1.15	0.4	0.3	0	45.2	38.7	0	139	123	0	34	33	33
2025	4	26	20	5	24	26.8	-2.2	1.15	0.3	0.2	0	45.2	38.7	0	139	123	0	34	33	33
2025	4	26	20	15	24	25.9	-3	1.15	0.5	0.5	0	45.6	39.1	0	140	124	0	34	33	34
2025	4	26	20	25	24	26.3	-3.1	1.15	0.4	0.3	0	45.6	39.6	0	140	125	0	34	33	34
2025	4	26	20	35	24	26.8	-3.3	1.15	0.3	0.2	0	45.6	39.1	0	140	124	0	34	33	34
2025	4	26	20	45	24	26.2	-2.6	1.15	0.3	0.2	0	45.6	39.6	0	140	125	0	34	33	33
2025	4	26	20	55	24	28.3	-3.4	1.15	0.3	0.2	0	45.6	39.1	0	140	124	0	34	33	34
2025	4	26	21	5	24	26.5	-1.8	1.15	0.4	0.3	0	46	39.6	0	140	125	0	33	33	33
2025	4	26	21	15	24	26.1	-3.1	1.15	0.5	0.5	0	45.6	39.6	0	140	125	0	34	33	34
2025	4	26	21	25	24	26.4	-1.9	1.15	0.5	0.4	0	45.6	39.6	0	140	125	0	34	33	34
2025	4	26	21	35	24	26.8	-2.8	1.15	0.4	0.3	0	45.2	39.1	0	140	124	0	35	33	35
2025	4	26	21	45	24	27.1	-2.2	1.15	0.3	0.2	0	46.4	39.1	0	142	124	0	34	33	34
2025	4	26	21	55	24	26.4	-3.2	1.15	0.4	0.3	0	46	39.1	0	141	124	0	34	33	34
2025	4	26	22	5	24	26.1	-3.4	1.15	0.3	0.2	0	46	39.1	0	141	124	0	34	33	34
2025	4	26	22	15	24	26.3	-2.5	1.15	0.3	0.2	0	45.6	39.1	0	140	124	0	34	33	34
2025	4	26	22	25	24	25.7	-3.2	1.15	0.3	0.2	0	46	39.1	0	141	124	0	34	33	33
2025	4	26	22	35	24	26.2	-2.9	1.15	0.4	0.3	0	45.6	39.1	0	141	124	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	26	22	45	24	26.3	-2.6	1.15	0.4	0.3	0	46	39.1	0	141	124	0	34	33	34
2025	4	26	22	55	24	26.1	-3.3	1.15	0.5	0.4	0	45.6	39.1	0	140	125	0	34	34	34
2025	4	26	23	5	24	26	-3.3	1.15	0.3	0.2	0	45.6	39.1	0	140	124	0	34	33	34
2025	4	26	23	15	24	27.3	-3	1.15	0.4	0.3	0	46	39.1	0	141	124	0	34	33	34
2025	4	26	23	25	24	26.1	-3.6	1.15	0.3	0.2	0	45.6	39.1	0	140	124	0	34	33	34
2025	4	26	23	35	24	25.2	-3.1	1.15	0.4	0.3	0	45.6	39.1	0	140	124	0	34	33	34
2025	4	26	23	45	24	26.5	-3.2	1.15	0.4	0.3	0	45.2	39.1	0	140	124	0	35	33	34
2025	4	26	23	55	24	25.9	-2.7	1.149	0.3	0.2	0	45.2	39.1	0	140	124	0	35	33	34
2025	4	27	0	5	24	25.4	-1.9	1.15	0.3	0.2	0	45.2	39.1	0	140	124	0	35	33	34
2025	4	27	0	15	24	25.9	-1.9	1.15	0.3	0.2	0	45.6	38.7	0	140	123	0	34	33	34
2025	4	27	0	25	24	25.6	-3.1	1.15	0.3	0.2	0	45.6	39.1	0	140	124	0	34	33	34
2025	4	27	0	35	24	26.1	-3	1.15	0.4	0.3	0	45.6	39.1	0	140	124	0	34	33	34
2025	4	27	0	45	24	26	-3.5	1.15	0.4	0.3	0	45.6	39.1	0	140	124	0	34	33	34
2025	4	27	0	55	24	26.3	-3.8	1.15	0.4	0.3	0	45.2	38.7	0	139	123	0	34	33	34
2025	4	27	1	5	24	25.7	-2.9	1.15	0.3	0.2	0	45.2	38.7	0	140	123	0	35	33	34
2025	4	27	1	15	24	26.5	-2.8	1.15	0.5	0.4	0	45.6	39.1	0	140	124	0	34	33	34
2025	4	27	1	25	24	25.6	-2.3	1.15	0.3	0.2	0	45.2	39.1	0	140	124	0	35	33	34
2025	4	27	1	35	24	25.2	-3.7	1.149	0.4	0.3	0	45.6	38.7	0	140	123	0	34	33	34
2025	4	27	1	45	24	25.4	-3	1.15	0.3	0.2	0	45.6	39.1	0	140	124	0	34	33	34
2025	4	27	1	55	24	26.1	-3.1	1.149	0.4	0.3	0	44.7	38.7	0	139	123	0	35	33	34
2025	4	27	2	5	24	25.5	-2.8	1.149	0.5	0.4	0	45.2	38.7	0	139	123	0	34	33	34
2025	4	27	2	15	24	26	-3.3	1.15	0.5	0.5	0	45.2	38.7	0	139	123	0	34	33	34
2025	4	27	2	25	24	26.4	-4.3	1.149	0.5	0.4	0	45.2	38.7	0	139	124	0	34	34	34
2025	4	27	2	35	24	26.5	-2.6	1.149	0.3	0.2	0	45.2	38.7	0	139	123	0	34	33	34
2025	4	27	2	45	24	27	-3.2	1.149	0.4	0.3	0	44.7	39.1	0	139	124	0	35	33	33
2025	4	27	2	55	24	26.3	-3.8	1.149	0.3	0.2	0	45.2	38.7	0	139	123	0	34	33	33
2025	4	27	3	5	24	25.8	-2.3	1.149	0.5	0.4	0	44.7	39.1	0	139	124	0	35	33	34
2025	4	27	3	15	24	25.5	-3.2	1.149	0.3	0.2	0	44.7	38.7	0	139	123	0	35	33	34
2025	4	27	3	25	24	26.1	-3	1.149	0.4	0.3	0	45.2	39.1	0	139	124	0	34	33	34
2025	4	27	3	35	24	26.8	-3.3	1.149	0.3	0.2	0	44.3	38.3	0	138	122	0	35	33	34
2025	4	27	3	45	24	26.4	-1.8	1.149	0.5	0.4	0	45.2	38.7	0	139	123	0	34	33	33
2025	4	27	3	55	24	26.4	-3.2	1.149	0.5	0.4	0	44.3	38.7	0	138	123	0	35	33	34
2025	4	27	4	5	24	26.5	-2.2	1.149	0.3	0.2	0	44.7	38.3	0	138	123	0	34	34	34
2025	4	27	4	15	24	26.9	-3.4	1.149	0.4	0.3	0	44.7	37.8	0	138	122	0	34	34	34
2025	4	27	4	25	24	26.4	-3.3	1.149	0.4	0.3	0	43.9	38.7	0	137	122	0	35	32	34
2025	4	27	4	35	24	26.3	-3.6	1.149	0.4	0.3	0	44.3	38.3	0	138	122	0	35	33	34
2025	4	27	4	45	24	26.4	-2.3	1.149	0.3	0.2	0	44.7	38.7	0	138	123	0	34	33	35
2025	4	27	4	55	24	26.1	-2.8	1.149	0.3	0.2	0	44.7	38.3	0	138	123	0	34	34	34
2025	4	27	5	5	24	26.3	-3.3	1.149	0.3	0.2	0	44.3	38.7	0	138	123	0	35	33	34
2025	4	27	5	15	24	25.9	-3	1.149	0.4	0.3	0	44.3	38.3	0	137	123	0	34	34	34
2025	4	27	5	25	24	26.1	-3.3	1.149	0.4	0.3	0	44.3	38.3	0	137	123	0	34	34	35
2025	4	27	5	35	24	25.4	-3.2	1.149	0.3	0.2	0	44.3	38.3	0	137	122	0	34	33	34
2025	4	27	5	45	24	26.4	-2.9	1.149	0.4	0.3	0	43.9	38.7	0	137	123	0	35	33	34
2025	4	27	5	55	24	25.7	-2.9	1.149	0.3	0.2	0	44.3	38.3	0	137	122	0	34	33	33
2025	4	27	6	5	24	26.1	-2.1	1.149	0.4	0.3	0	43.4	37.8	0	136	122	0	35	34	33
2025	4	27	6	15	24	25.9	-2.7	1.149	0.4	0.3	0	43	37.4	0	135	121	0	35	34	34
2025	4	27	6	25	24	25.8	-2.6	1.149	0.3	0.2	0	43.4	37.8	0	135	121	0	34	33	34
2025	4	27	6	35	24	26	-2.9	1.149	0.3	0.2	0	43.4	37.8	0	135	121	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	27	6	45	24	26.1	-2.3	1.149	0.4	0.3	0	42.6	37.8	0	134	120	0	35	32	34
2025	4	27	6	55	24	25.3	-3.8	1.149	0.4	0.3	0	42.6	37.4	0	134	120	0	35	33	34
2025	4	27	7	5	24	26.1	-3.4	1.149	0.4	0.3	0	42.6	37.4	0	134	120	0	35	33	34
2025	4	27	7	15	24	25.9	-3.5	1.149	0.4	0.3	0	42.6	37.4	0	133	120	0	34	33	34
2025	4	27	7	25	24	25.7	-3	1.149	0.3	0.2	0	41.7	37	0	132	119	0	35	33	34
2025	4	27	7	35	24	26.3	-3.4	1.149	0.4	0.3	0	42.1	37.4	0	133	120	0	35	33	34
2025	4	27	7	45	24	26.1	-2.6	1.149	0.4	0.3	0	42.1	37	0	133	120	0	35	34	34
2025	4	27	7	55	24	25.4	-3.6	1.149	0.4	0.3	0	42.6	37	0	133	120	0	34	34	35
2025	4	27	8	5	24	24.9	-3	1.149	0.4	0.3	0	42.1	37	0	132	119	0	34	33	34
2025	4	27	8	15	24	24.7	-2.6	1.149	0.4	0.3	0	42.1	37	0	133	120	0	35	34	34
2025	4	27	8	25	24	24.1	-3	1.149	0.5	0.4	0	41.7	36.5	0	132	119	0	35	34	34
2025	4	27	8	35	24	26.4	-2.6	1.149	0.3	0.2	0	42.1	37	0	132	119	0	34	33	34
2025	4	27	8	45	24	25.7	-3	1.149	0.3	0.2	0	42.1	37	0	133	119	0	35	33	34
2025	4	27	8	55	24	24.6	-3.2	1.149	0.3	0.2	0	42.6	37.4	0	133	120	0	34	33	34
2025	4	27	9	5	24	25.5	-3.3	1.149	0.3	0.2	0	42.6	37.4	0	133	120	0	34	33	34
2025	4	27	9	15	24	25.8	-2.6	1.149	0.4	0.3	0	42.6	37.4	0	133	120	0	34	33	34
2025	4	27	9	25	24	25.9	-2.9	1.15	0.4	0.3	0	42.6	37	0	133	119	0	34	33	33
2025	4	27	9	35	24	26	-4	1.15	0.3	0.2	0	42.6	37.4	0	133	120	0	34	33	33
2025	4	27	9	45	24	25.3	-3.8	1.15	0.4	0.3	0	42.1	37	0	133	119	0	35	33	34
2025	4	27	9	55	24	26.2	-3.2	1.15	0.4	0.3	0	41.7	36.5	0	131	118	0	34	33	34
2025	4	27	10	5	24	25.5	-2.5	1.15	0.3	0.2	0	42.1	37	0	133	120	0	35	34	34
2025	4	27	10	15	24	26.5	-2.7	1.15	0.4	0.3	0	42.6	37.8	0	134	121	0	35	33	34
2025	4	27	10	25	24	25.8	-2.1	1.15	0.4	0.3	0	42.6	37.4	0	133	120	0	34	33	34
2025	4	27	10	35	24	26	-3.7	1.15	0.3	0.2	0	42.1	37	0	133	119	0	35	33	34
2025	4	27	10	45	24	26.4	-3.7	1.15	0.3	0.2	0	42.1	36.5	0	132	118	0	34	33	34
2025	4	27	10	55	24	25.8	-1.8	1.15	0.4	0.3	0	42.1	36.5	0	132	119	0	34	34	34
2025	4	27	11	5	24	27	-3.8	1.15	0.3	0.2	0	42.1	37	0	132	118	0	34	32	34
2025	4	27	11	15	24	26.6	-3.6	1.15	0.3	0.2	0	41.7	36.5	0	131	118	0	34	33	34
2025	4	27	11	25	24	26.6	-3	1.15	0.4	0.3	0	42.1	37	0	132	119	0	34	33	34
2025	4	27	11	35	24	25.2	-2.8	1.15	0.5	0.4	0	42.6	37.8	0	133	121	0	34	33	34
2025	4	27	11	45	24	25.5	-2.8	1.15	0.3	0.2	0	42.1	36.5	0	132	119	0	34	34	34
2025	4	27	11	55	24	25.3	-3	1.15	0.3	0.2	0	42.1	37	0	132	119	0	34	33	34
2025	4	27	12	5	24	26.5	-3.4	1.15	0.3	0.2	0	42.1	37	0	132	119	0	34	33	34
2025	4	27	12	15	24	25.3	-3.9	1.15	0.5	0.4	0	41.7	36.5	0	131	118	0	34	33	33
2025	4	27	12	25	24	26.7	-2.6	1.15	0.5	0.4	0	41.7	36.5	0	131	118	0	34	33	34
2025	4	27	12	35	24	25.8	-3.2	1.15	0.4	0.3	0	41.7	36.1	0	131	118	0	34	34	34
2025	4	27	12	45	24	25	-2.2	1.15	0.4	0.3	0	41.7	36.5	0	132	118	0	35	33	33
2025	4	27	12	55	24	26.6	-3	1.15	0.3	0.2	0	41.3	36.5	0	131	118	0	35	33	34
2025	4	27	13	5	24	25.9	-3.7	1.149	0.3	0.2	0	42.1	36.5	0	132	118	0	34	33	34
2025	4	27	13	15	24	25.2	-1.8	1.15	0.3	0.2	0	41.3	36.5	0	131	118	0	35	33	34
2025	4	27	13	25	24	26.4	-3	1.15	0.3	0.2	0	41.3	37	0	131	119	0	35	33	34
2025	4	27	13	35	24	25.9	-3.7	1.149	0.3	0.2	0	42.1	37	0	132	119	0	34	33	34
2025	4	27	13	45	24	24.8	-2.7	1.149	0.4	0.3	0	41.7	37.4	0	131	119	0	34	32	34
2025	4	27	13	55	24	24.9	-4.6	1.149	0.3	0.2	0	41.7	36.5	0	131	118	0	34	33	34
2025	4	27	14	5	24	25.2	-2.8	1.149	0.4	0.3	0	41.7	37	0	131	119	0	34	33	34
2025	4	27	14	15	24	25.9	-3.5	1.148	0.5	0.4	0	41.3	37	0	131	119	0	35	33	33
2025	4	27	14	25	24	25.5	-2.6	1.149	0.5	0.4	0	41.7	36.1	0	131	118	0	34	34	33
2025	4	27	14	35	24	25.4	-2.5	1.148	0.3	0.2	0	41.3	36.5	0	130	118	0	34	33	33

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	4	27	14	45	24	25.7	-4	1.148	0.4	0.3	0	41.7	36.5	0	131	118	0	34	33	33	
2025	4	27	14	55	24	25.7	-3.1	1.148	0.4	0.3	0	41.7	36.5	0	131	118	0	34	33	34	
2025	4	27	15	5	24	25.7	-3.1	1.147	0.4	0.3	0	41.7	37	0	131	118	0	34	32	33	
2025	4	27	15	15	24	26.4	-3.1	1.147	0.4	0.3	0	41.3	36.5	0	130	118	0	34	33	34	
2025	4	27	15	25	24	24.8	-2.4	1.147	0.3	0.2	0	41.3	36.5	0	130	118	0	34	33	33	
2025	4	27	15	35	24	25	-3.5	1.147	0.3	0.2	0	41.7	37	0	131	119	0	34	33	34	
2025	4	27	15	45	24	25.8	-2.7	1.146	0.3	0.2	0	41.7	36.5	0	131	118	0	34	33	33	
2025	4	27	15	55	24	25.9	-3.6	1.146	0.3	0.2	0	42.1	37.4	0	132	120	0	34	33	33	
2025	4	27	16	5	24	25.7	-3.3	1.147	0.5	0.4	0	41.7	37.4	0	132	120	0	35	33	34	
2025	4	27	16	15	24	25	-2.7	1.146	0.4	0.3	0	42.1	37.4	0	132	120	0	34	33	34	
2025	4	27	16	25	24	25.4	-3.1	1.146	0.4	0.3	0	42.1	37.4	0	132	120	0	34	33	34	
2025	4	27	16	35	24	26.6	-2.7	1.146	0.3	0.2	0	41.3	37	0	131	119	0	35	33	34	
2025	4	27	16	45	24	25.7	-2.6	1.146	0.5	0.4	0	42.1	37.4	0	132	120	0	34	33	33	
2025	4	27	16	55	24	25.9	-3.5	1.146	0.3	0.2	0	42.1	37.4	0	132	120	0	34	33	34	
2025	4	27	17	5	24	25.6	-3.2	1.146	0.3	0.2	0	41.7	37.8	0	132	120	0	35	32	34	
2025	4	27	17	15	24	26.6	-3	1.146	0.3	0.2	0	42.1	37	0	132	120	0	34	34	33	
2025	4	27	17	25	24	25.2	-3	1.146	0.4	0.3	0	42.1	37.8	0	132	120	0	34	32	33	
2025	4	27	17	35	24	26.7	-3.3	1.146	0.4	0.3	0	41.7	37	0	131	119	0	34	33	34	
2025	4	27	17	45	24	26.5	-2.3	1.146	0.5	0.4	0	41.7	37	0	131	119	0	34	33	34	
2025	4	27	17	55	24	25.7	-3.5	1.145	0.4	0.3	0	42.1	37	0	132	119	0	34	33	33	
2025	4	27	18	5	24	26.3	-4	1.145	0.3	0.2	0	41.7	37.4	0	131	120	0	34	33	34	
2025	4	27	18	15	24	25.9	-2.6	1.145	0.3	0.2	0	42.6	37.4	0	132	120	0	33	33	34	
2025	4	27	18	25	24	25.7	-3.3	1.146	0.4	0.3	0	42.1	37	0	132	119	0	34	33	34	
2025	4	27	18	35	24	26.3	-3.9	1.146	0.4	0.3	0	42.1	37.4	0	132	120	0	34	33	34	
2025	4	27	18	45	24	25.2	-2.5	1.145	0.5	0.5	0	42.6	37.4	0	133	120	0	34	33	33	
2025	4	27	18	55	24	25.5	-2.6	1.145	0.3	0.2	0	42.1	37.8	0	132	120	0	34	32	34	
2025	4	27	19	5	24	26.3	-3.2	1.145	0.5	0.4	0	42.1	37.4	0	132	120	0	34	33	34	
2025	4	27	19	15	24	25.5	-2.6	1.145	0.3	0.2	0	42.1	37.4	0	132	120	0	34	33	34	
2025	4	27	19	25	24	26.5	-3.1	1.145	0.3	0.2	0	42.1	37.8	0	132	121	0	34	33	34	
2025	4	27	19	35	24	25.8	-3.8	1.145	0.4	0.3	0	42.6	37.8	0	133	121	0	34	33	34	
2025	4	27	19	45	24	26.6	-2.9	1.145	0.5	0.4	0	42.1	37.8	0	133	121	0	35	33	33	
2025	4	27	19	55	24	24.7	-3	1.145	0.4	0.3	0	41.7	37.8	0	132	121	0	35	33	34	
2025	4	27	20	5	24	27	-4.4	1.145	0.4	0.3	0	42.1	38.3	0	133	122	0	35	33	34	
2025	4	27	20	15	24	25.8	-3.6	1.145	0.3	0.2	0	42.1	38.3	0	133	122	0	35	33	33	
2025	4	27	20	25	24	25.7	-2.5	1.145	0.3	0.2	0	43	38.7	0	134	123	0	34	33	34	
2025	4	27	20	35	24	26.2	-2.7	1.144	0.3	0.2	0	43.4	39.1	0	136	124	0	35	33	34	
2025	4	27	20	45	24	25.4	-3.4	1.144	0.4	0.3	0	43	39.6	0	135	124	0	35	32	33	
2025	4	27	20	55	24	25.3	-2.7	1.144	0.5	0.4	0	43	39.1	0	135	124	0	35	33	33	
2025	4	27	21	5	24	25.3	-2.7	1.144	0.5	0.4	0	43.9	39.1	0	136	124	0	34	33	33	
2025	4	27	21	15	24	26.7	-2.7	1.144	0.4	0.3	0	43.4	38.3	0	135	123	0	34	34	34	
2025	4	27	21	25	24	25.7	-3	1.144	0.3	0.2	0	43.4	39.1	0	135	123	0	34	32	34	
2025	4	27	21	35	24	25.9	-3.2	1.144	0.5	0.4	0	43.4	39.1	0	135	123	0	34	32	33	
2025	4	27	21	45	24	26.5	-3.2	1.144	0.3	0.2	0	43.4	39.1	0	135	124	0	34	33	34	
2025	4	27	21	55	24	25.2	-2.8	1.144	0.4	0.3	0	43.4	39.1	0	135	124	0	34	33	34	
2025	4	27	22	5	24	24.7	-4.1	1.144	0.3	0.2	0	43	38.7	0	134	123	0	34	33	33	
2025	4	27	22	15	24	25.7	-2.9	1.143	0.5	0.4	0	43.4	39.1	0	135	124	0	34	33	34	
2025	4	27	22	25	24	25.8	-3	1.143	0.3	0.2	0	43.4	39.1	0	135	124	0	34	33	33	
2025	4	27	22	35	24	25.3	-2.8	1.143	0.3	0.2	0	43	39.6	0	135	125	0	35	33	33	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	27	22	45	24	25.2	-3.5	1.143	0.3	0.2	0	43	38.7	0	134	124	0	34	34	34
2025	4	27	22	55	24	25	-3.6	1.143	0.3	0.2	0	42.6	39.1	0	134	124	0	35	33	34
2025	4	27	23	5	24	25.2	-3.9	1.143	0.3	0.2	0	43	39.1	0	134	124	0	34	33	34
2025	4	27	23	15	24	25.2	-3.5	1.143	0.4	0.3	0	42.6	39.1	0	134	124	0	35	33	34
2025	4	27	23	25	24	24.7	-3.1	1.143	0.4	0.3	0	43	38.7	0	134	124	0	34	34	34
2025	4	27	23	35	24	25.2	-2.4	1.143	0.4	0.3	0	43	38.7	0	134	124	0	34	34	34
2025	4	27	23	45	24	24.8	-2.5	1.142	0.3	0.2	0	43	39.1	0	134	124	0	34	33	33
2025	4	27	23	55	24	25.2	-2.1	1.142	0.4	0.3	0	43	39.1	0	134	124	0	34	33	34
2025	4	28	0	5	24	24.4	-2.7	1.142	0.3	0.2	0	43	39.1	0	134	124	0	34	33	34
2025	4	28	0	15	24	26.4	-2.6	1.143	0.4	0.3	0	42.6	39.1	0	133	124	0	34	33	34
2025	4	28	0	25	24	24.7	-3	1.142	0.3	0.2	0	42.6	38.7	0	133	124	0	34	34	34
2025	4	28	0	35	24	25.8	-2.1	1.142	0.4	0.3	0	42.1	38.7	0	133	124	0	35	34	34
2025	4	28	0	45	24	25.6	-2.7	1.142	0.3	0.2	0	43.4	39.1	0	135	124	0	34	33	33
2025	4	28	0	55	24	24.7	-2.9	1.142	0.5	0.4	0	43.4	39.1	0	135	124	0	34	33	34
2025	4	28	1	5	24	26	-3.1	1.142	0.5	0.4	0	43.4	39.1	0	135	124	0	34	33	34
2025	4	28	1	15	24	25.8	-3	1.142	0.3	0.2	0	43.4	39.1	0	135	124	0	34	33	34
2025	4	28	1	25	24	25.7	-3.4	1.142	0.4	0.3	0	43.4	39.1	0	135	124	0	34	33	34
2025	4	28	1	35	24	25.2	-2.9	1.142	0.3	0.2	0	43.9	39.1	0	135	124	0	33	33	34
2025	4	28	1	45	24	24.6	-0.9	1.142	0.5	0.5	0	43.4	39.1	0	135	124	0	34	33	35
2025	4	28	1	55	24	26.1	-2.5	1.142	0.3	0.2	0	43.4	40	0	136	125	0	35	32	34
2025	4	28	2	5	24	25.5	-3.6	1.142	0.3	0.2	0	43	39.1	0	135	124	0	35	33	33
2025	4	28	2	15	24	25.7	-2.2	1.142	0.3	0.2	0	43	39.1	0	135	124	0	35	33	34
2025	4	28	2	25	24	26.2	-3.4	1.142	0.4	0.3	0	42.6	39.1	0	134	124	0	35	33	34
2025	4	28	2	35	24	26.1	-3.3	1.142	0.4	0.3	0	43	39.6	0	135	125	0	35	33	35
2025	4	28	2	45	24	25.5	-4	1.142	0.5	0.4	0	43	39.1	0	134	124	0	34	33	34
2025	4	28	2	55	24	25.1	-1.8	1.142	0.3	0.2	0	43	39.1	0	135	125	0	35	34	35
2025	4	28	3	5	24	25.2	-3.4	1.142	0.3	0.2	0	42.6	38.7	0	134	124	0	35	34	34
2025	4	28	3	15	24	25.9	-2.7	1.142	0.5	0.4	0	43.4	39.1	0	134	124	0	33	33	34
2025	4	28	3	25	24	26.5	-2.6	1.142	0.4	0.3	0	43.4	39.1	0	135	124	0	34	33	34
2025	4	28	3	35	24	25.2	-2.6	1.142	0.3	0.2	0	43	38.7	0	134	124	0	34	34	34
2025	4	28	3	45	24	25.7	-2.4	1.142	0.5	0.4	0	42.6	39.1	0	134	124	0	35	33	34
2025	4	28	3	55	24	26.5	-2.4	1.142	0.3	0.2	0	42.6	39.1	0	134	124	0	35	33	34
2025	4	28	4	5	24	26.5	-2	1.142	0.3	0.2	0	43	39.1	0	134	124	0	34	33	34
2025	4	28	4	15	24	25.1	-1.4	1.142	0.5	0.5	0	43	39.1	0	134	124	0	34	33	35
2025	4	28	4	25	24	26.3	-1.8	1.142	0.4	0.3	0	43	39.6	0	134	125	0	34	33	34
2025	4	28	4	35	24	26.1	-2.8	1.142	0.4	0.3	0	43	39.1	0	134	124	0	34	33	34
2025	4	28	4	45	24	25.1	-2.9	1.142	0.5	0.4	0	43	39.1	0	134	124	0	34	33	34
2025	4	28	4	55	24	26	-2.3	1.142	0.3	0.2	0	43	39.1	0	134	124	0	34	33	34
2025	4	28	5	5	24	26.3	-2.8	1.141	0.3	0.2	0	43	39.1	0	134	124	0	34	33	34
2025	4	28	5	15	24	25.7	-2	1.142	0.3	0.2	0	43.4	39.6	0	135	125	0	34	33	34
2025	4	28	5	25	24	25.2	-3	1.142	0.5	0.4	0	42.6	38.7	0	134	124	0	35	34	34
2025	4	28	5	35	24	26.4	-2.7	1.142	0.4	0.3	0	42.6	39.1	0	133	124	0	34	33	34
2025	4	28	5	45	24	25.1	-1.4	1.142	0.4	0.3	0	43	39.1	0	134	124	0	34	33	34
2025	4	28	5	55	24	25.7	-2.9	1.142	0.5	0.4	0	42.6	39.1	0	133	124	0	34	33	34
2025	4	28	6	5	24	25.5	-2	1.142	0.3	0.2	0	42.6	38.7	0	133	124	0	34	34	34
2025	4	28	6	15	24	26.6	-3.3	1.142	0.3	0.2	0	42.1	38.7	0	132	123	0	34	33	34
2025	4	28	6	25	24	26.5	-2.8	1.142	0.4	0.3	0	41.7	38.7	0	132	123	0	35	33	34
2025	4	28	6	35	24	24.9	-3.4	1.142	0.3	0.2	0	43.4	38.3	0	135	122	0	34	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	28	6	45	24	24.8	-2.6	1.142	0.3	0.2	0	44.7	38.7	0	138	122	0	34	32	34
2025	4	28	6	55	24	25.1	-2.6	1.142	0.3	0.2	0	44.3	38.3	0	138	122	0	35	33	34
2025	4	28	7	5	24	26.3	-3	1.142	0.3	0.2	0	43.9	37.8	0	136	121	0	34	33	34
2025	4	28	7	15	24	24.4	-1.7	1.142	0.4	0.3	0	44.3	38.7	0	137	122	0	34	32	34
2025	4	28	7	25	24	23.6	-1.4	1.142	0.4	0.3	0	44.3	38.7	0	137	122	0	34	32	34
2025	4	28	7	35	24	25.3	-2.4	1.142	0.3	0.2	0	43.9	37.8	0	136	121	0	34	33	34
2025	4	28	7	45	24	26	-3.5	1.142	0.3	0.2	0	43.9	38.3	0	137	122	0	35	33	34
2025	4	28	7	55	24	25.1	-2.7	1.142	0.5	0.4	0	44.3	38.3	0	137	122	0	34	33	34
2025	4	28	8	5	24	25	-2.6	1.142	0.5	0.4	0	43.9	38.3	0	137	122	0	35	33	34
2025	4	28	8	15	24	24.8	-2.7	1.142	0.4	0.3	0	43.9	38.7	0	136	122	0	34	32	34
2025	4	28	8	25	24	24.9	-1.7	1.142	0.4	0.3	0	44.3	38.3	0	137	122	0	34	33	34
2025	4	28	8	35	24	25.9	-2.6	1.142	0.3	0.2	0	43.9	38.7	0	137	122	0	35	32	34
2025	4	28	8	45	24	24.8	-3.1	1.142	0.3	0.2	0	43.9	38.3	0	136	122	0	34	33	34
2025	4	28	8	55	24	25.5	-1.8	1.142	0.4	0.3	0	44.3	38.3	0	137	122	0	34	33	33
2025	4	28	9	5	24	25.4	-1.9	1.142	0.4	0.3	0	44.7	39.1	0	138	124	0	34	33	33
2025	4	28	9	15	24	25.7	-3	1.143	0.3	0.2	0	44.7	39.1	0	138	123	0	34	32	34
2025	4	28	9	25	24	25.1	-2.7	1.143	0.3	0.2	0	44.3	38.7	0	137	123	0	34	33	34
2025	4	28	9	35	24	24.8	-2.4	1.143	0.3	0.2	0	45.2	39.1	0	139	124	0	34	33	34
2025	4	28	9	45	24	25.5	-2	1.143	0.5	0.4	0	45.2	39.6	0	139	125	0	34	33	33
2025	4	28	9	55	24	26.9	-2.9	1.143	0.3	0.2	0	45.6	38.7	0	140	123	0	34	33	34
2025	4	28	10	5	24	25.5	-2.9	1.143	0.3	0.2	0	45.6	38.7	0	140	123	0	34	33	34
2025	4	28	10	15	24	25.7	-2.3	1.143	0.4	0.3	0	45.2	38.7	0	139	123	0	34	33	34
2025	4	28	10	25	24	26.5	-3.8	1.143	0.5	0.4	0	45.2	39.6	0	140	124	0	35	32	33
2025	4	28	10	35	24	27.2	-3.6	1.144	0.3	0.2	0	45.2	38.3	0	139	122	0	34	33	33
2025	4	28	10	45	24	25.8	-2.1	1.144	0.4	0.3	0	45.2	38.7	0	139	122	0	34	32	34
2025	4	28	10	55	24	24.7	-1.6	1.144	0.3	0.2	0	45.2	38.7	0	139	123	0	34	33	34
2025	4	28	11	5	24	25.7	-3.1	1.144	0.3	0.2	0	44.3	38.3	0	138	122	0	35	33	34
2025	4	28	11	15	24	26.6	-3.2	1.144	0.4	0.3	0	44.3	38.7	0	138	122	0	35	32	33
2025	4	28	11	25	24	25.5	-2.7	1.144	0.5	0.4	0	44.7	38.3	0	138	122	0	34	33	33
2025	4	28	11	35	24	26.6	-3.5	1.144	0.5	0.4	0	44.7	38.7	0	138	122	0	34	32	34
2025	4	28	11	45	24	26.4	-3.8	1.144	0.4	0.3	0	45.2	38.3	0	138	122	0	33	33	33
2025	4	28	11	55	24	25.3	-3.3	1.144	0.3	0.2	0	45.2	38.3	0	139	122	0	34	33	33
2025	4	28	12	5	24	26.3	-2.6	1.144	0.3	0.2	0	44.7	38.7	0	138	122	0	34	32	34
2025	4	28	12	15	24	25.3	-2.6	1.144	0.4	0.3	0	45.2	38.3	0	139	122	0	34	33	34
2025	4	28	12	25	24	25.3	-3	1.144	0.3	0.2	0	44.7	38.7	0	138	122	0	34	32	33
2025	4	28	12	35	24	25.4	-2.9	1.145	0.4	0.3	0	44.7	38.7	0	139	123	0	35	33	33
2025	4	28	12	45	24	25.4	-3.1	1.144	0.5	0.4	0	44.3	39.1	0	138	123	0	35	32	34
2025	4	28	12	55	24	24.9	-2.8	1.145	0.4	0.3	0	44.7	38.7	0	138	122	0	34	32	33
2025	4	28	13	5	24	25	-2	1.145	0.3	0.2	0	44.7	39.1	0	138	123	0	34	32	34
2025	4	28	13	15	24	25.9	-2.9	1.145	0.3	0.2	0	44.7	38.3	0	138	122	0	34	33	33
2025	4	28	13	25	24	25.2	-2.4	1.145	0.4	0.3	0	45.6	38.7	0	139	123	0	33	33	34
2025	4	28	13	35	24	25.7	-1.9	1.145	0.5	0.4	0	44.7	38.3	0	138	122	0	34	33	34
2025	4	28	13	45	24	26.3	-3.1	1.145	0.4	0.3	0	44.7	38.3	0	138	122	0	34	33	34
2025	4	28	13	55	24	25.1	-2.3	1.145	0.5	0.5	0	44.7	38.3	0	138	122	0	34	33	34
2025	4	28	14	5	24	25.4	-1.9	1.145	0.3	0.2	0	44.3	38.7	0	138	122	0	35	32	33
2025	4	28	14	15	24	25.6	-2.2	1.145	0.3	0.2	0	44.3	38.7	0	137	122	0	34	32	33
2025	4	28	14	25	24	25.1	-3.1	1.145	0.3	0.2	0	44.3	37.8	0	137	121	0	34	33	33
2025	4	28	14	35	24	26	-2.7	1.145	0.5	0.4	0	44.7	38.3	0	138	122	0	34	33	34

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	4	28	14	45	24	25.7	-3.2	1.145	0.3	0.2	0	45.2	38.7	0	138	122	0	33	32	33	
2025	4	28	14	55	24	25.6	-2.8	1.145	0.3	0.2	0	44.7	38.3	0	138	122	0	34	33	33	
2025	4	28	15	5	24	24.6	-3.1	1.145	0.4	0.3	0	44.7	39.1	0	138	123	0	34	32	34	
2025	4	28	15	15	24	25.3	-2	1.145	0.3	0.2	0	44.7	38.7	0	138	123	0	34	33	33	
2025	4	28	15	25	24	25.7	-2.3	1.145	0.3	0.2	0	44.7	39.1	0	138	123	0	34	32	33	
2025	4	28	15	35	24	25	-2.7	1.145	0.3	0.2	0	45.2	38.7	0	138	123	0	33	33	33	
2025	4	28	15	45	24	26.3	-2.7	1.145	0.3	0.2	0	44.7	39.6	0	139	124	0	35	32	34	
2025	4	28	15	55	24	25.9	-3	1.145	0.4	0.3	0	44.7	39.1	0	138	123	0	34	32	34	
2025	4	28	16	5	24	25.4	-3	1.145	0.4	0.3	0	44.3	38.3	0	137	122	0	34	33	34	
2025	4	28	16	15	24	26.5	-2.2	1.145	0.4	0.3	0	45.2	39.1	0	138	123	0	33	32	34	
2025	4	28	16	25	24	25.2	-2.4	1.145	0.4	0.3	0	45.6	38.7	0	139	123	0	33	33	33	
2025	4	28	16	35	24	25	-3.4	1.145	0.3	0.2	0	44.7	38.7	0	138	123	0	34	33	33	
2025	4	28	16	45	24	26	-2.7	1.145	0.4	0.3	0	45.2	38.7	0	139	123	0	34	33	33	
2025	4	28	16	55	24	25.1	-2	1.145	0.4	0.3	0	45.6	39.6	0	139	124	0	33	32	33	
2025	4	28	17	5	24	25.8	-3.5	1.145	0.4	0.3	0	45.6	38.7	0	140	124	0	34	34	33	
2025	4	28	17	15	24	24.6	-3.3	1.145	0.4	0.3	0	46	39.6	0	140	124	0	33	32	33	
2025	4	28	17	25	24	25.4	-2	1.145	0.5	0.4	0	45.2	39.6	0	139	124	0	34	32	33	
2025	4	28	17	35	24	24.9	-2	1.145	0.3	0.2	0	45.6	39.1	0	139	124	0	33	33	33	
2025	4	28	17	45	24	26	-2.2	1.145	0.3	0.2	0	45.2	39.1	0	139	124	0	34	33	34	
2025	4	28	17	55	24	26.4	-3	1.145	0.5	0.4	0	45.2	39.6	0	139	124	0	34	32	33	
2025	4	28	18	5	24	24.3	-2.7	1.145	0.4	0.3	0	45.6	39.1	0	140	124	0	34	33	33	
2025	4	28	18	15	24	26.6	-2.8	1.145	0.4	0.3	0	45.2	39.1	0	139	124	0	34	33	34	
2025	4	28	18	25	24	26.6	-2	1.145	0.4	0.3	0	45.2	39.6	0	139	124	0	34	32	33	
2025	4	28	18	35	24	26.3	-2.9	1.145	0.5	0.4	0	45.2	39.6	0	139	124	0	34	32	33	
2025	4	28	18	45	24	24	-1.9	1.145	0.3	0.2	0	45.2	39.1	0	139	124	0	34	33	33	
2025	4	28	18	55	24	26.6	-2.2	1.145	0.3	0.2	0	45.2	39.1	0	139	124	0	34	33	33	
2025	4	28	19	5	24	25.7	-2.2	1.145	0.4	0.3	0	45.6	39.1	0	140	124	0	34	33	33	
2025	4	28	19	15	24	25.7	-2.9	1.145	0.5	0.5	0	45.2	39.6	0	139	124	0	34	32	34	
2025	4	28	19	25	24	27	-3.1	1.145	0.3	0.2	0	45.2	39.6	0	139	124	0	34	32	34	
2025	4	28	19	35	24	25.6	-2.3	1.145	0.4	0.3	0	45.2	39.1	0	139	124	0	34	33	33	
2025	4	28	19	45	24	26.2	-1.8	1.145	0.5	0.4	0	45.6	39.6	0	140	125	0	34	33	34	
2025	4	28	19	55	24	25.3	-2.9	1.145	0.3	0.2	0	46	40	0	140	125	0	33	32	33	
2025	4	28	20	5	24	25.4	-2.8	1.145	0.4	0.3	0	45.6	39.6	0	140	125	0	34	33	34	
2025	4	28	20	15	24	25.9	-2.3	1.145	0.3	0.2	0	46.4	40.4	0	142	126	0	34	32	33	
2025	4	28	20	25	24	24.4	-1.8	1.145	0.4	0.3	0	46.9	40.4	0	143	127	0	34	33	33	
2025	4	28	20	35	24	25.8	-3.1	1.145	0.5	0.4	0	47.7	40.4	0	144	127	0	33	33	33	
2025	4	28	20	45	24	25.8	-1.7	1.145	0.4	0.3	0	48.2	40.9	0	146	127	0	34	32	34	
2025	4	28	20	55	24	24.8	-2.6	1.145	0.4	0.3	0	47.7	40.4	0	145	127	0	34	33	33	
2025	4	28	21	5	24	25.1	-2	1.145	0.5	0.4	0	47.3	40.9	0	144	127	0	34	32	34	
2025	4	28	21	15	24	25.8	-1.9	1.145	0.5	0.4	0	47.7	40.9	0	145	127	0	34	32	33	
2025	4	28	21	25	24	26.3	-3.4	1.145	0.5	0.4	0	46.9	40.4	0	144	127	0	35	33	34	
2025	4	28	21	35	24	26	-2.3	1.145	0.3	0.2	0	47.3	40.9	0	144	127	0	34	32	34	
2025	4	28	21	45	24	25.9	-3.1	1.145	0.3	0.2	0	47.7	40.4	0	145	127	0	34	33	33	
2025	4	28	21	55	24	26.1	-3.5	1.145	0.3	0.2	0	47.7	40.9	0	145	127	0	34	32	33	
2025	4	28	22	5	24	26.9	-2.1	1.145	0.4	0.3	0	47.3	40	0	144	126	0	34	33	34	
2025	4	28	22	15	24	25.9	-1.8	1.144	0.4	0.3	0	47.3	40.9	0	144	127	0	34	32	34	
2025	4	28	22	25	24	24.9	-2.5	1.145	0.4	0.3	0	47.7	40	0	144	126	0	33	33	33	
2025	4	28	22	35	24	25.9	-2.6	1.145	0.4	0.3	0	46.9	40	0	144	126	0	35	33	34	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	28	22	45	24	25.4	-3.2	1.145	0.3	0.2	0	47.3	40	0	144	126	0	34	33	34
2025	4	28	22	55	24	25.7	-2.3	1.145	0.4	0.3	0	47.3	40	0	144	126	0	34	33	34
2025	4	28	23	5	24	25.9	-2.1	1.145	0.3	0.2	0	46.9	40	0	143	126	0	34	33	33
2025	4	28	23	15	24	25.8	-2.4	1.145	0.3	0.2	0	46.9	40	0	143	126	0	34	33	34
2025	4	28	23	25	24	25.8	-2.5	1.145	0.3	0.2	0	46.9	40	0	143	126	0	34	33	33
2025	4	28	23	35	24	26.8	-2.5	1.144	0.3	0.2	0	46.9	40	0	143	126	0	34	33	33
2025	4	28	23	45	24	24.9	-2.1	1.145	0.5	0.4	0	46.9	40	0	143	126	0	34	33	33
2025	4	28	23	55	24	26	-2.3	1.145	0.3	0.2	0	46.4	40	0	143	126	0	35	33	34
2025	4	29	0	5	24	26.2	-2.6	1.145	0.3	0.2	0	46.4	39.6	0	142	125	0	34	33	34
2025	4	29	0	15	24	25.4	-2.9	1.145	0.3	0.2	0	46.4	40.4	0	143	126	0	35	32	34
2025	4	29	0	25	24	25.1	-2.9	1.145	0.4	0.3	0	46.9	40.4	0	143	126	0	34	32	34
2025	4	29	0	35	24	24.4	-2.8	1.145	0.3	0.2	0	46	39.6	0	142	125	0	35	33	33
2025	4	29	0	45	24	26	-3.5	1.145	0.4	0.3	0	46.9	40	0	143	126	0	34	33	34
2025	4	29	0	55	24	25.2	-3.5	1.145	0.4	0.3	0	46.4	40	0	142	126	0	34	33	34
2025	4	29	1	5	24	26	-1.7	1.145	0.4	0.3	0	46	40	0	142	126	0	35	33	34
2025	4	29	1	15	24	25.5	-3	1.145	0.4	0.3	0	46.4	39.6	0	142	125	0	34	33	33
2025	4	29	1	25	24	26.2	-3.1	1.145	0.3	0.2	0	46.4	39.6	0	142	125	0	34	33	34
2025	4	29	1	35	24	25.4	-2.9	1.145	0.3	0.2	0	46.9	40	0	143	126	0	34	33	34
2025	4	29	1	45	24	25.9	-3.2	1.145	0.4	0.3	0	45.2	39.1	0	140	125	0	35	34	34
2025	4	29	1	55	24	25.9	-4.4	1.145	0.3	0.2	0	46	40	0	141	126	0	34	33	34
2025	4	29	2	5	24	25.2	-3.1	1.145	0.4	0.3	0	46	39.6	0	142	125	0	35	33	34
2025	4	29	2	15	24	25.7	-4.1	1.145	0.3	0.2	0	46	39.6	0	141	125	0	34	33	33
2025	4	29	2	25	24	26.2	-1.9	1.146	0.3	0.2	0	45.6	39.6	0	140	125	0	34	33	33
2025	4	29	2	35	24	24.5	-3.1	1.145	0.3	0.2	0	45.6	39.1	0	141	125	0	35	34	34
2025	4	29	2	45	24	25.5	-2.3	1.145	0.5	0.4	0	46.4	40	0	142	126	0	34	33	33
2025	4	29	2	55	24	25.4	-3.1	1.146	0.3	0.2	0	45.6	39.6	0	141	125	0	35	33	34
2025	4	29	3	5	24	25	-2.6	1.145	0.4	0.3	0	45.6	39.6	0	140	125	0	34	33	34
2025	4	29	3	15	24	26.5	-3.3	1.146	0.5	0.4	0	45.6	39.6	0	140	125	0	34	33	34
2025	4	29	3	25	24	26.3	-2.5	1.146	0.3	0.2	0	46	39.6	0	141	125	0	34	33	33
2025	4	29	3	35	24	25.7	-4	1.146	0.3	0.2	0	45.6	40	0	140	125	0	34	32	34
2025	4	29	3	45	24	25.9	-2.1	1.146	0.3	0.2	0	45.6	39.6	0	141	125	0	35	33	34
2025	4	29	3	55	24	25.2	-3.3	1.145	0.4	0.3	0	45.6	39.6	0	140	125	0	34	33	34
2025	4	29	4	5	24	25.2	-1.3	1.146	0.4	0.3	0	45.6	40	0	141	126	0	35	33	33
2025	4	29	4	15	24	25.5	-2	1.146	0.3	0.2	0	45.6	39.6	0	140	125	0	34	33	34
2025	4	29	4	25	24	26.1	-1.9	1.146	0.4	0.3	0	45.2	40	0	140	125	0	35	32	33
2025	4	29	4	35	24	25.8	-2.3	1.146	0.4	0.3	0	45.6	39.6	0	140	125	0	34	33	34
2025	4	29	4	45	24	25.8	-3.3	1.147	0.4	0.3	0	45.6	39.6	0	140	125	0	34	33	34
2025	4	29	4	55	24	24.3	-2.6	1.147	0.5	0.4	0	46.4	39.6	0	142	125	0	34	33	34
2025	4	29	5	5	24	26.7	-3.2	1.146	0.3	0.2	0	46	39.6	0	141	125	0	34	33	34
2025	4	29	5	15	24	26	-1.8	1.146	0.4	0.3	0	46.4	40	0	142	126	0	34	33	33
2025	4	29	5	25	24	24.7	-2.6	1.146	0.3	0.2	0	46.4	39.1	0	142	125	0	34	34	35
2025	4	29	5	35	24	25.2	-1.7	1.147	0.3	0.2	0	46.4	40	0	142	126	0	34	33	34
2025	4	29	5	45	24	26.3	-2	1.147	0.4	0.3	0	45.6	40	0	141	125	0	35	32	34
2025	4	29	5	55	24	26.7	-2.6	1.146	0.5	0.4	0	45.6	39.6	0	141	125	0	35	33	33
2025	4	29	6	5	24	27.1	-1.9	1.147	0.3	0.2	0	46	39.1	0	141	124	0	34	33	33
2025	4	29	6	15	24	26.9	-3.7	1.147	0.3	0.2	0	45.6	39.6	0	140	124	0	34	32	34
2025	4	29	6	25	24	25.9	-2.2	1.148	0.4	0.3	0	45.6	39.1	0	140	124	0	34	33	34
2025	4	29	6	35	24	25.8	-2.1	1.148	0.4	0.3	0	45.6	38.7	0	139	123	0	33	33	34

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	4	29	6	45	24	25.3	-3.4	1.148	0.3	0.2	0	45.2	38.7	0	139	123	0	34	33	33	
2025	4	29	6	55	24	26	-2.6	1.148	0.5	0.4	0	45.2	38.7	0	139	123	0	34	33	34	
2025	4	29	7	5	24	26.2	-3.1	1.148	0.5	0.4	0	45.2	38.3	0	139	122	0	34	33	34	
2025	4	29	7	15	24	26.1	-2.6	1.149	0.3	0.2	0	44.7	38.3	0	138	122	0	34	33	34	
2025	4	29	7	25	24	25.7	-2.6	1.149	0.3	0.2	0	45.2	39.1	0	139	123	0	34	32	34	
2025	4	29	7	35	24	26	-2.5	1.149	0.4	0.3	0	44.3	38.3	0	138	122	0	35	33	34	
2025	4	29	7	45	24	25.9	-2.2	1.149	0.3	0.2	0	45.2	38.7	0	139	123	0	34	33	34	
2025	4	29	7	55	24	26.3	-3.9	1.148	0.4	0.3	0	45.2	39.1	0	139	123	0	34	32	34	
2025	4	29	8	5	24	26.1	-2.6	1.149	0.3	0.2	0	44.7	38.7	0	138	123	0	34	33	33	
2025	4	29	8	15	24	25.3	-3.4	1.149	0.3	0.2	0	44.3	38.7	0	138	123	0	35	33	33	
2025	4	29	8	25	24	27.3	-2.3	1.149	0.3	0.2	0	44.7	38.3	0	138	122	0	34	33	34	
2025	4	29	8	35	24	26.8	-2.2	1.149	0.3	0.2	0	44.3	38.3	0	138	122	0	35	33	34	
2025	4	29	8	45	24	25.8	-1.7	1.149	0.3	0.2	0	44.7	39.1	0	138	123	0	34	32	33	
2025	4	29	8	55	24	25.1	-2.7	1.149	0.4	0.3	0	45.6	39.1	0	139	124	0	33	33	34	
2025	4	29	9	5	24	24.4	-2.8	1.148	0.3	0.2	0	44.7	38.7	0	138	123	0	34	33	34	
2025	4	29	9	15	24	25.9	-2.4	1.149	0.4	0.3	0	45.2	38.7	0	139	124	0	34	34	34	
2025	4	29	9	25	24	25.5	-3.1	1.148	0.4	0.3	0	44.7	38.7	0	138	123	0	34	33	33	
2025	4	29	9	35	24	26.9	-3.2	1.148	0.5	0.4	0	44.7	38.7	0	138	123	0	34	33	34	
2025	4	29	9	45	24	25.5	-1.7	1.149	0.5	0.4	0	45.2	39.1	0	139	124	0	34	33	33	
2025	4	29	9	55	24	26.6	-3.2	1.148	0.5	0.4	0	44.7	38.7	0	138	123	0	34	33	34	
2025	4	29	10	5	24	25.5	-2.4	1.149	0.3	0.2	0	44.7	38.7	0	138	123	0	34	33	33	
2025	4	29	10	15	24	25.7	-2.5	1.15	0.4	0.3	0	44.3	38.7	0	137	123	0	34	33	34	
2025	4	29	10	25	24	25.3	-2.7	1.149	0.5	0.4	0	44.3	38.7	0	137	123	0	34	33	34	
2025	4	29	10	35	24	25.4	-1.8	1.147	0.4	0.3	0	44.3	38.7	0	137	123	0	34	33	33	
2025	4	29	10	45	24	26.7	-3.3	1.147	0.3	0.2	0	44.3	37.8	0	137	122	0	34	34	34	
2025	4	29	10	55	24	26.9	-3.5	1.146	0.3	0.2	0	44.7	38.7	0	138	123	0	34	33	33	
2025	4	29	11	5	24	26.1	-3.1	1.146	0.4	0.3	0	44.3	38.3	0	137	122	0	34	33	33	
2025	4	29	11	15	24	25.2	-2.4	1.146	0.3	0.2	0	44.3	38.3	0	137	122	0	34	33	33	
2025	4	29	11	25	24	24.9	-2.7	1.147	0.4	0.3	0	44.3	38.7	0	137	123	0	34	33	34	
2025	4	29	11	35	24	24.3	-1.7	1.147	0.4	0.3	0	44.7	38.7	0	138	123	0	34	33	34	
2025	4	29	11	45	24	26.5	-2.7	1.147	0.3	0.2	0	43.9	38.7	0	137	123	0	35	33	34	
2025	4	29	11	55	24	24.9	-3.1	1.147	0.5	0.4	0	44.7	38.7	0	137	123	0	33	33	33	
2025	4	29	12	5	24	26.4	-2.5	1.147	0.3	0.2	0	44.3	38.3	0	137	122	0	34	33	34	
2025	4	29	12	15	24	26.6	-2.2	1.147	0.4	0.3	0	44.3	38.7	0	137	122	0	34	32	34	
2025	4	29	12	25	24	26.9	-4.3	1.147	0.4	0.3	0	44.3	38.3	0	136	121	0	33	32	33	
2025	4	29	12	35	24	25.8	-2.5	1.147	0.4	0.3	0	44.3	38.7	0	137	122	0	34	32	33	
2025	4	29	12	45	24	25.1	-3.1	1.147	0.5	0.4	0	44.7	38.7	0	137	122	0	33	32	34	
2025	4	29	12	55	24	25.4	-2.3	1.147	0.3	0.2	0	44.3	38.3	0	137	122	0	34	33	33	
2025	4	29	13	5	24	26.5	-3.4	1.147	0.4	0.3	0	43.9	38.3	0	136	122	0	34	33	34	
2025	4	29	13	15	24	25.4	-2.3	1.147	0.4	0.3	0	43.9	37.8	0	136	121	0	34	33	33	
2025	4	29	13	25	24	26	-2.6	1.147	0.3	0.2	0	43.9	38.3	0	136	122	0	34	33	33	
2025	4	29	13	35	24	25.7	-2.9	1.147	0.3	0.2	0	43.9	38.7	0	136	122	0	34	32	34	
2025	4	29	13	45	24	24.7	-3.2	1.147	0.4	0.3	0	43.9	38.7	0	136	122	0	34	32	33	
2025	4	29	13	55	24	25.9	-3.1	1.147	0.3	0.2	0	44.3	39.1	0	137	123	0	34	32	33	
2025	4	29	14	5	24	25.5	-3	1.147	0.4	0.3	0	43.9	38.7	0	136	122	0	34	32	33	
2025	4	29	14	15	24	25.9	-3.4	1.147	0.3	0.2	0	43.9	38.3	0	136	122	0	34	33	33	
2025	4	29	14	25	24	26	-2.5	1.147	0.5	0.4	0	44.3	39.1	0	137	123	0	34	32	34	
2025	4	29	14	35	24	25.5	-3.1	1.147	0.3	0.2	0	43.9	38.7	0	136	122	0	34	32	34	

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	4	29	14	45	24	26.4	-3.4	1.147	0.4	0.3	0	44.3	38.7	0	137	123	0	34	33	33	
2025	4	29	14	55	24	25.4	-2.7	1.147	0.3	0.2	0	44.3	38.7	0	137	123	0	34	33	33	
2025	4	29	15	5	24	26.8	-2.8	1.147	0.3	0.2	0	44.3	38.3	0	136	122	0	33	33	33	
2025	4	29	15	15	24	25.8	-4	1.147	0.4	0.3	0	43.9	38.3	0	136	122	0	34	33	34	
2025	4	29	15	25	24	26.4	-2.9	1.147	0.4	0.3	0	43.9	38.7	0	136	122	0	34	32	34	
2025	4	29	15	35	24	25.7	-2.9	1.147	0.4	0.3	0	43.9	38.3	0	136	122	0	34	33	33	
2025	4	29	15	45	24	26.6	-3.5	1.147	0.3	0.2	0	44.3	38.3	0	137	122	0	34	33	33	
2025	4	29	15	55	24	25.7	-2.9	1.147	0.4	0.3	0	43.9	38.3	0	136	122	0	34	33	33	
2025	4	29	16	5	24	26.2	-2.9	1.147	0.4	0.3	0	44.3	38.7	0	137	123	0	34	33	33	
2025	4	29	16	15	24	26.6	-2.2	1.147	0.3	0.2	0	43.9	38.7	0	137	123	0	35	33	33	
2025	4	29	16	25	24	26.5	-3.3	1.147	0.4	0.3	0	44.3	38.7	0	137	123	0	34	33	34	
2025	4	29	16	35	24	25.1	-2.7	1.147	0.3	0.2	0	44.7	39.1	0	137	123	0	33	32	33	
2025	4	29	16	45	24	25.5	-3.5	1.147	0.5	0.4	0	44.3	39.1	0	137	123	0	34	32	33	
2025	4	29	16	55	24	26.1	-2.5	1.147	0.3	0.2	0	43.9	38.7	0	136	122	0	34	32	33	
2025	4	29	17	5	24	27	-2.2	1.147	0.4	0.3	0	43.4	38.3	0	136	122	0	35	33	34	
2025	4	29	17	15	24	25.6	-2.6	1.147	0.3	0.2	0	43.9	38.7	0	136	122	0	34	32	33	
2025	4	29	17	25	24	26.6	-2.8	1.147	0.4	0.3	0	43.4	38.7	0	135	122	0	34	32	33	
2025	4	29	17	35	24	25.3	-1.7	1.147	0.4	0.3	0	43.9	38.7	0	136	122	0	34	32	33	
2025	4	29	17	45	24	25.1	-3.1	1.147	0.3	0.2	0	44.3	38.7	0	136	122	0	33	32	34	
2025	4	29	17	55	24	25.7	-1.1	1.147	0.4	0.3	0	44.3	38.7	0	137	123	0	34	33	32	
2025	4	29	18	5	24	26.5	-3.2	1.147	0.5	0.4	0	43.9	38.3	0	136	122	0	34	33	34	
2025	4	29	18	15	24	27	-3.4	1.147	0.5	0.4	0	43.9	38.7	0	136	122	0	34	32	34	
2025	4	29	18	25	24	25.9	-2.2	1.147	0.4	0.3	0	44.3	38.7	0	137	122	0	34	32	33	
2025	4	29	18	35	24	26.7	-2.9	1.147	0.3	0.2	0	44.3	38.7	0	136	122	0	33	32	33	
2025	4	29	18	45	24	26.2	-3.9	1.147	0.4	0.3	0	43.9	38.7	0	136	122	0	34	32	34	
2025	4	29	18	55	24	25.4	-2.6	1.147	0.4	0.3	0	44.3	38.7	0	136	122	0	33	32	33	
2025	4	29	19	5	24	26.6	-4	1.147	0.4	0.3	0	43.9	38.3	0	136	122	0	34	33	33	
2025	4	29	19	15	24	25.4	-2.2	1.147	0.3	0.2	0	44.3	39.1	0	137	123	0	34	32	33	
2025	4	29	19	25	24	24.5	-2.7	1.147	0.3	0.2	0	44.3	38.7	0	137	123	0	34	33	33	
2025	4	29	19	35	24	26.9	-2.3	1.147	0.4	0.3	0	44.3	38.7	0	137	123	0	34	33	33	
2025	4	29	19	45	24	26.4	-1.7	1.147	0.4	0.3	0	44.3	39.1	0	138	124	0	35	33	34	
2025	4	29	19	55	24	26.8	-1.8	1.147	0.5	0.4	0	44.7	39.6	0	138	124	0	34	32	33	
2025	4	29	20	5	24	26.2	-2.9	1.147	0.3	0.2	0	45.2	39.6	0	139	125	0	34	33	34	
2025	4	29	20	15	24	25.8	-3.5	1.147	0.4	0.3	0	44.7	40	0	138	125	0	34	32	34	
2025	4	29	20	25	24	26.5	-2.6	1.147	0.4	0.3	0	45.6	40	0	140	126	0	34	33	33	
2025	4	29	20	35	24	26.2	-3.1	1.147	0.4	0.3	0	45.6	39.6	0	139	125	0	33	33	33	
2025	4	29	20	45	24	27.3	-4.4	1.148	0.3	0.2	0	45.6	40	0	140	126	0	34	33	33	
2025	4	29	20	55	24	26.6	-2.8	1.148	0.3	0.2	0	45.2	40.4	0	139	126	0	34	32	34	
2025	4	29	21	5	24	26.3	-3.5	1.147	0.4	0.3	0	45.2	39.6	0	139	125	0	34	33	33	
2025	4	29	21	15	24	25.2	-2.4	1.148	0.3	0.2	0	45.2	40	0	139	126	0	34	33	34	
2025	4	29	21	25	24	27	-3	1.148	0.3	0.2	0	44.7	40.4	0	139	126	0	35	32	34	
2025	4	29	21	35	24	26.9	-3.8	1.149	0.3	0.2	0	45.2	39.6	0	139	125	0	34	33	33	
2025	4	29	21	45	24	27	-3.5	1.149	0.3	0.2	0	45.2	39.6	0	139	125	0	34	33	33	
2025	4	29	21	55	24	26.1	-3.6	1.15	0.4	0.3	0	45.2	39.6	0	139	125	0	34	33	34	
2025	4	29	22	5	24	26.2	-3.5	1.15	0.4	0.3	0	45.2	39.6	0	139	125	0	34	33	33	
2025	4	29	22	15	24	26.5	-2.9	1.151	0.4	0.3	0	44.7	39.6	0	139	125	0	35	33	33	
2025	4	29	22	25	24	26	-3.5	1.151	0.3	0.2	0	45.2	39.6	0	139	125	0	34	33	34	
2025	4	29	22	35	24	25.2	-2.8	1.151	0.5	0.5	0	45.2	40	0	139	125	0	34	32	34	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	29	22	45	24	26.2	-3.6	1.152	0.3	0.2	0	45.2	40	0	139	125	0	34	32	34
2025	4	29	22	55	24	25.6	-3.5	1.152	0.3	0.2	0	45.6	39.6	0	139	125	0	33	33	33
2025	4	29	23	5	24	26.5	-3.7	1.152	0.4	0.3	0	45.2	39.6	0	139	125	0	34	33	34
2025	4	29	23	15	24	26.3	-3.7	1.152	0.5	0.4	0	45.2	39.1	0	139	124	0	34	33	33
2025	4	29	23	25	24	27.4	-3.5	1.152	0.5	0.4	0	45.6	39.6	0	140	125	0	34	33	34
2025	4	29	23	35	24	25.6	-2.6	1.152	0.4	0.3	0	45.6	39.6	0	140	125	0	34	33	34
2025	4	29	23	45	24	25.8	-3.1	1.152	0.5	0.4	0	45.6	39.6	0	140	125	0	34	33	33
2025	4	29	23	55	24	25.5	-2.9	1.152	0.3	0.2	0	45.6	40	0	140	125	0	34	32	34
2025	4	30	0	5	24	25.6	-3.4	1.152	0.3	0.2	0	45.6	40	0	140	125	0	34	32	34
2025	4	30	0	15	24	25.3	-2.4	1.152	0.4	0.3	0	45.2	39.6	0	140	125	0	35	33	33
2025	4	30	0	25	24	25.7	-3.3	1.152	0.3	0.2	0	45.2	39.1	0	139	124	0	34	33	34
2025	4	30	0	35	24	27.3	-3	1.152	0.3	0.2	0	45.2	39.6	0	139	124	0	34	32	34
2025	4	30	0	45	24	25.9	-3	1.152	0.4	0.3	0	45.2	39.1	0	138	124	0	33	33	34
2025	4	30	0	55	24	26.4	-2.6	1.152	0.4	0.3	0	44.7	39.6	0	138	124	0	34	32	34
2025	4	30	1	5	24	25.4	-2.2	1.152	0.3	0.2	0	45.2	39.1	0	139	124	0	34	33	34
2025	4	30	1	15	24	26.9	-1.7	1.152	0.3	0.2	0	45.2	39.1	0	139	124	0	34	33	34
2025	4	30	1	25	24	26.8	-3	1.152	0.3	0.2	0	44.7	39.1	0	138	124	0	34	33	33
2025	4	30	1	35	24	26.2	-3.3	1.152	0.5	0.4	0	44.7	39.1	0	138	124	0	34	33	34
2025	4	30	1	45	24	26.1	-2.6	1.152	0.3	0.2	0	44.7	39.1	0	138	124	0	34	33	34
2025	4	30	1	55	24	26.2	-3	1.153	0.5	0.4	0	44.3	39.1	0	138	124	0	35	33	33
2025	4	30	2	5	24	25.1	-2.9	1.153	0.4	0.3	0	44.7	39.1	0	138	124	0	34	33	33
2025	4	30	2	15	24	26.6	-2.2	1.153	0.3	0.2	0	44.7	39.6	0	138	124	0	34	32	34
2025	4	30	2	25	24	26.4	-3.5	1.152	0.3	0.2	0	44.7	38.7	0	138	123	0	34	33	33
2025	4	30	2	35	24	25.4	-2.5	1.153	0.4	0.3	0	44.7	38.7	0	138	123	0	34	33	34
2025	4	30	2	45	24	25.8	-3.2	1.153	0.3	0.2	0	44.7	39.1	0	138	124	0	34	33	33
2025	4	30	2	55	24	25.8	-2.9	1.152	0.5	0.4	0	44.7	39.1	0	138	123	0	34	32	33
2025	4	30	3	5	24	25.9	-3.1	1.152	0.4	0.3	0	44.3	38.7	0	137	123	0	34	33	33
2025	4	30	3	15	24	25.6	-2.6	1.152	0.4	0.3	0	44.7	39.1	0	138	123	0	34	32	33
2025	4	30	3	25	24	26.9	-3.5	1.153	0.3	0.2	0	43.9	39.1	0	137	123	0	35	32	33
2025	4	30	3	35	24	27	-3.6	1.152	0.4	0.3	0	44.3	38.7	0	137	123	0	34	33	34
2025	4	30	3	45	24	26.6	-3.4	1.152	0.4	0.3	0	44.7	38.7	0	138	123	0	34	33	33
2025	4	30	3	55	24	24.9	-2.8	1.152	0.4	0.3	0	44.7	38.7	0	138	123	0	34	33	33
2025	4	30	4	5	24	25.9	-2.8	1.152	0.4	0.3	0	43.9	38.7	0	137	123	0	35	33	34
2025	4	30	4	15	24	26.4	-3.5	1.152	0.3	0.2	0	44.7	39.1	0	138	123	0	34	32	34
2025	4	30	4	25	24	26.9	-3	1.152	0.5	0.4	0	44.7	39.1	0	138	123	0	34	32	33
2025	4	30	4	35	24	25.6	-4	1.152	0.3	0.2	0	45.2	39.6	0	138	124	0	33	32	34
2025	4	30	4	45	24	26.3	-3.7	1.152	0.4	0.3	0	44.3	38.7	0	137	123	0	34	33	33
2025	4	30	4	55	24	26.1	-2.7	1.152	0.3	0.2	0	44.7	39.6	0	138	124	0	34	32	33
2025	4	30	5	5	24	26	-3.2	1.152	0.4	0.3	0	44.3	39.1	0	137	123	0	34	32	34
2025	4	30	5	15	24	26.6	-3	1.152	0.4	0.3	0	44.3	39.1	0	137	123	0	34	32	33
2025	4	30	5	25	24	26.3	-3.4	1.152	0.4	0.3	0	44.3	38.7	0	137	123	0	34	33	33
2025	4	30	5	35	24	27	-3.9	1.151	0.4	0.3	0	43.4	38.7	0	136	123	0	35	33	34
2025	4	30	5	45	24	25.7	-3.4	1.151	0.3	0.2	0	44.3	39.1	0	137	123	0	34	32	34
2025	4	30	5	55	24	25.9	-3.3	1.151	0.3	0.2	0	43.9	38.3	0	136	122	0	34	33	33
2025	4	30	6	5	24	26.3	-3.1	1.15	0.3	0.2	0	43.9	38.3	0	136	122	0	34	33	33
2025	4	30	6	15	24	25.2	-2.9	1.15	0.3	0.2	0	43.9	38.7	0	136	122	0	34	32	34
2025	4	30	6	25	24	26.4	-2.6	1.15	0.5	0.4	0	43.9	38.3	0	136	122	0	34	33	34
2025	4	30	6	35	24	25.8	-1.9	1.149	0.3	0.2	0	43.9	37.8	0	136	121	0	34	33	34

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	4	30	6	45	24	25.3	-3.5	1.149	0.4	0.3	0	43.4	38.3	0	135	121	0	34	32	33	
2025	4	30	6	55	24	25.5	-2.9	1.149	0.3	0.2	0	43.9	38.3	0	135	121	0	33	32	33	
2025	4	30	7	5	24	25.6	-3.1	1.148	0.5	0.4	0	43.4	37.8	0	135	121	0	34	33	34	
2025	4	30	7	15	24	25.8	-2.4	1.148	0.5	0.4	0	43.4	38.3	0	135	121	0	34	32	33	
2025	4	30	7	25	24	25	-3.6	1.148	0.4	0.3	0	43	38.3	0	134	121	0	34	32	34	
2025	4	30	7	35	24	26.2	-2.3	1.148	0.3	0.2	0	43.4	38.3	0	135	121	0	34	32	34	
2025	4	30	7	45	24	26.2	-2.8	1.148	0.3	0.2	0	43	37.4	0	134	120	0	34	33	34	
2025	4	30	7	55	24	26.6	-3.9	1.148	0.5	0.4	0	43	37.4	0	134	120	0	34	33	33	
2025	4	30	8	5	24	27.1	-3.3	1.148	0.3	0.2	0	43	37.4	0	134	120	0	34	33	34	
2025	4	30	8	15	24	26.6	-4.3	1.148	0.3	0.2	0	43	37.4	0	134	120	0	34	33	34	
2025	4	30	8	25	24	26.7	-3.5	1.148	0.3	0.2	0	43.4	37.8	0	135	121	0	34	33	33	
2025	4	30	8	35	24	26.9	-4.1	1.148	0.4	0.3	0	43.4	38.3	0	135	121	0	34	32	33	
2025	4	30	8	45	24	26.3	-2.4	1.148	0.4	0.3	0	43.4	37.8	0	135	121	0	34	33	34	
2025	4	30	8	55	24	26.2	-2.4	1.148	0.4	0.3	0	43	38.3	0	134	121	0	34	32	33	
2025	4	30	9	5	24	25.6	-2.8	1.148	0.3	0.2	0	43.4	38.3	0	135	121	0	34	32	33	
2025	4	30	9	15	24	25.7	-3.4	1.148	0.3	0.2	0	43.4	37.4	0	135	121	0	34	34	33	
2025	4	30	9	25	24	25.9	-2.5	1.148	0.3	0.2	0	43	37.4	0	134	120	0	34	33	33	
2025	4	30	9	35	24	27.5	-2.7	1.148	0.3	0.2	0	43	37.4	0	134	120	0	34	33	33	
2025	4	30	9	45	24	26.8	-3.5	1.148	0.3	0.2	0	43	37.4	0	134	120	0	34	33	34	
2025	4	30	9	55	24	26.9	-2.2	1.148	0.3	0.2	0	43.4	38.3	0	135	121	0	34	32	33	
2025	4	30	10	5	24	26.4	-2.4	1.148	0.3	0.2	0	43.4	38.3	0	135	122	0	34	33	34	
2025	4	30	10	15	24	27.2	-2.1	1.148	0.4	0.3	0	43.4	38.3	0	135	122	0	34	33	34	
2025	4	30	10	25	24	26.3	-3.8	1.147	0.4	0.3	0	43.9	38.3	0	135	122	0	33	33	32	
2025	4	30	10	35	24	27.2	-3.5	1.148	0.3	0.2	0	43.4	38.7	0	135	122	0	34	32	33	
2025	4	30	10	45	24	25.6	-2.6	1.148	0.3	0.2	0	43.9	38.3	0	136	122	0	34	33	33	
2025	4	30	10	55	24	26.3	-3.5	1.148	0.4	0.3	0	43.4	38.7	0	135	122	0	34	32	33	
2025	4	30	11	5	24	26.2	-2.6	1.148	0.3	0.2	0	43.9	38.3	0	136	122	0	34	33	33	
2025	4	30	11	15	24	25.9	-3.1	1.148	0.3	0.2	0	43.4	38.7	0	135	122	0	34	32	34	
2025	4	30	11	25	24	25.2	-2.2	1.148	0.4	0.3	0	43.9	38.7	0	136	123	0	34	33	33	
2025	4	30	11	35	24	26.2	-3.1	1.148	0.3	0.2	0	43.9	38.7	0	135	122	0	33	32	33	
2025	4	30	11	45	24	26.1	-2.4	1.148	0.3	0.2	0	43.4	38.7	0	135	122	0	34	32	34	
2025	4	30	11	55	24	25.9	-2.9	1.148	0.4	0.3	0	43.4	38.3	0	135	122	0	34	33	33	
2025	4	30	12	5	24	25.6	-2.3	1.148	0.4	0.3	0	43.4	38.7	0	135	122	0	34	32	33	
2025	4	30	12	15	24	27.1	-3	1.148	0.3	0.2	0	43.4	38.7	0	135	122	0	34	32	33	
2025	4	30	12	25	24	24.9	-3.2	1.148	0.4	0.3	0	43	37.8	0	134	121	0	34	33	33	
2025	4	30	12	35	24	26.7	-2.1	1.148	0.4	0.3	0	43.4	39.1	0	135	123	0	34	32	33	
2025	4	30	12	45	24	25.7	-3.3	1.148	0.3	0.2	0	43	37.8	0	134	121	0	34	33	33	
2025	4	30	12	55	24	25.5	-2.3	1.148	0.3	0.2	0	43	38.3	0	134	121	0	34	32	33	
2025	4	30	13	5	24	25.5	-2.3	1.148	0.5	0.4	0	43.4	38.7	0	135	122	0	34	32	33	
2025	4	30	13	15	24	26.5	-3.5	1.148	0.3	0.2	0	42.6	38.3	0	134	121	0	35	32	33	
2025	4	30	13	25	24	25.7	-3.3	1.148	0.4	0.3	0	43	38.3	0	133	121	0	33	32	33	
2025	4	30	13	35	24	25.9	-3.2	1.148	0.4	0.3	0	43.4	38.3	0	134	121	0	33	32	34	
2025	4	30	13	45	24	26.1	-3.2	1.148	0.3	0.2	0	42.6	37.4	0	133	120	0	34	33	33	
2025	4	30	13	55	24	26.3	-2.2	1.148	0.5	0.5	0	42.1	37.4	0	132	120	0	34	33	33	
2025	4	30	14	5	24	26.6	-3.6	1.148	0.3	0.2	0	42.1	37.4	0	132	119	0	34	32	34	
2025	4	30	14	15	24	26.3	-2.3	1.148	0.4	0.3	0	42.6	37	0	132	119	0	33	33	33	
2025	4	30	14	25	24	26.4	-2.4	1.148	0.3	0.2	0	42.1	37.4	0	132	119	0	34	32	33	
2025	4	30	14	35	24	27.1	-1.4	1.147	0.3	0.2	0	43	37.8	0	133	120	0	33	32	34	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	30	14	45	24	25.4	-2.3	1.148	0.3	0.2	0	43.9	39.1	0	135	123	0	33	32	33
2025	4	30	14	55	24	27.1	-2.4	1.148	0.3	0.2	0	43.4	38.7	0	135	122	0	34	32	33
2025	4	30	15	5	24	25.4	-3.1	1.148	0.4	0.3	0	42.6	37.8	0	133	120	0	34	32	33
2025	4	30	15	15	24	25.9	-2.1	1.148	0.5	0.4	0	43	38.3	0	134	121	0	34	32	33
2025	4	30	15	25	24	26.9	-2.6	1.148	0.3	0.2	0	43	38.3	0	134	121	0	34	32	34
2025	4	30	15	35	24	27.1	-2.8	1.147	0.3	0.2	0	43.4	38.3	0	134	121	0	33	32	34
2025	4	30	15	45	24	26.8	-3.1	1.147	0.3	0.2	0	43	37.8	0	134	121	0	34	33	33
2025	4	30	15	55	24	27.6	-2.5	1.147	0.4	0.3	0	43	37.8	0	134	121	0	34	33	33
2025	4	30	16	5	24	26.8	-1.8	1.147	0.4	0.3	0	43.4	38.7	0	135	122	0	34	32	33
2025	4	30	16	15	24	26.7	-2.7	1.147	0.3	0.2	0	43	38.7	0	134	122	0	34	32	33
2025	4	30	16	25	24	26.2	-2.2	1.147	0.3	0.2	0	46.4	38.7	0	141	122	0	33	32	33
2025	4	30	16	35	24	25.3	-2.8	1.147	0.4	0.3	0	46.4	38.3	0	141	122	0	33	33	34
2025	4	30	16	45	24	26.8	-3	1.147	0.4	0.3	0	46	38.7	0	141	122	0	34	32	34
2025	4	30	16	55	24	26.3	-3.2	1.147	0.4	0.3	0	46	38.3	0	141	122	0	34	33	33
2025	4	30	17	5	24	25.9	-2.7	1.147	0.3	0.2	0	46.4	38.3	0	141	122	0	33	33	33
2025	4	30	17	15	24	27.4	-2.4	1.147	0.5	0.4	0	46	38.3	0	141	121	0	34	32	33
2025	4	30	17	25	24	27	-2.8	1.147	0.3	0.2	0	46.4	38.3	0	141	122	0	33	33	33
2025	4	30	17	35	24	26.1	-2.6	1.147	0.5	0.4	0	46.4	38.7	0	142	123	0	34	33	33
2025	4	30	17	45	24	26.7	-2.1	1.147	0.4	0.3	0	46.9	39.1	0	142	123	0	33	32	33
2025	4	30	17	55	24	26.3	-2.2	1.147	0.4	0.3	0	46.4	38.7	0	142	123	0	34	33	33
2025	4	30	18	5	24	26.8	-2.5	1.147	0.3	0.2	0	46.4	39.1	0	142	123	0	34	32	33
2025	4	30	18	15	24	26.7	-2.6	1.147	0.4	0.3	0	46.9	38.7	0	143	123	0	34	33	33
2025	4	30	18	25	24	25.9	-2.4	1.147	0.4	0.3	0	46.9	38.7	0	142	123	0	33	33	33
2025	4	30	18	35	24	27	-1.9	1.146	0.4	0.3	0	46.9	38.7	0	143	123	0	34	33	33
2025	4	30	18	45	24	27	-1.8	1.146	0.5	0.4	0	46	39.1	0	142	123	0	35	32	33
2025	4	30	18	55	24	27.6	-2.3	1.146	0.4	0.3	0	46.9	39.1	0	142	123	0	33	32	33
2025	4	30	19	5	24	26.1	-1.7	1.146	0.3	0.2	0	46.4	39.1	0	142	123	0	34	32	33
2025	4	30	19	15	24	26.9	-2.4	1.146	0.5	0.5	0	46.4	38.7	0	142	123	0	34	33	33
2025	4	30	19	25	24	26.7	-2.4	1.146	0.3	0.2	0	46.4	38.7	0	142	123	0	34	33	33
2025	4	30	19	35	24	26.4	-1.9	1.146	0.5	0.4	0	47.3	39.6	0	144	124	0	34	32	33
2025	4	30	19	45	24	27.8	-2.1	1.146	0.4	0.3	0	47.3	39.1	0	143	124	0	33	33	34
2025	4	30	19	55	24	25.4	-2.9	1.146	0.4	0.3	0	47.7	39.6	0	144	125	0	33	33	33
2025	4	30	20	5	24	26.4	-2.1	1.146	0.3	0.2	0	46.9	40	0	144	125	0	35	32	34
2025	4	30	20	15	24	26.3	-3.4	1.146	0.4	0.3	0	47.7	40	0	145	126	0	34	33	33
2025	4	30	20	25	24	26.4	-3	1.146	0.3	0.2	0	47.3	40	0	144	125	0	34	32	33
2025	4	30	20	35	24	26.2	-2.2	1.145	0.3	0.2	0	47.3	40.4	0	144	126	0	34	32	34
2025	4	30	20	45	24	26.6	-2.8	1.146	0.4	0.3	0	47.3	39.6	0	144	125	0	34	33	33
2025	4	30	20	55	24	25.8	-1.8	1.145	0.4	0.3	0	47.3	40	0	144	126	0	34	33	34
2025	4	30	21	5	24	28.1	-2.6	1.145	0.3	0.2	0	46.9	39.6	0	143	125	0	34	33	34
2025	4	30	21	15	24	27.1	-2.5	1.145	0.3	0.2	0	46.9	39.6	0	143	125	0	34	33	33
2025	4	30	21	25	24	26.7	-2.6	1.145	0.4	0.3	0	46.9	39.1	0	143	124	0	34	33	33
2025	4	30	21	35	24	27.2	-2.6	1.145	0.4	0.3	0	46.9	39.6	0	143	125	0	34	33	33
2025	4	30	21	45	24	26	-2.4	1.145	0.3	0.2	0	47.3	40	0	144	125	0	34	32	33
2025	4	30	21	55	24	26.8	-2.6	1.145	0.3	0.2	0	47.3	40	0	144	125	0	34	32	33
2025	4	30	22	5	24	26	-2.6	1.145	0.4	0.3	0	47.3	39.6	0	144	125	0	34	33	33
2025	4	30	22	15	24	25.9	-2.3	1.145	0.3	0.2	0	46.9	39.1	0	143	124	0	34	33	33
2025	4	30	22	25	24	26.1	-3.3	1.145	0.3	0.2	0	46.9	39.1	0	143	124	0	34	33	33
2025	4	30	22	35	24	26.5	-2.9	1.145	0.4	0.3	0	46.9	39.1	0	143	124	0	34	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	4	30	22	45	24	24	-1.1	1.145	0.3	0.2	0	46	29.7	0	141	102	0	34	33	34
2025	4	30	22	55	24	25.8	-2.6	1.145	0.3	0.2	0	46.4	39.1	0	143	124	0	35	33	33
2025	4	30	23	5	24	26.2	-3.1	1.145	0.4	0.3	0	47.3	39.1	0	143	124	0	33	33	34
2025	4	30	23	15	24	25.2	-2.9	1.145	0.3	0.2	0	46.9	38.7	0	143	123	0	34	33	34
2025	4	30	23	25	24	26.9	-2.8	1.145	0.5	0.4	0	46.9	39.6	0	143	124	0	34	32	34
2025	4	30	23	35	24	27.1	-4.2	1.145	0.4	0.3	0	46.4	38.7	0	142	123	0	34	33	33
2025	4	30	23	45	24	26.6	-3.1	1.145	0.4	0.3	0	46.4	39.1	0	142	123	0	34	32	33
2025	4	30	23	55	24	24.8	-3	1.145	0.4	0.3	0	46.9	39.1	0	143	124	0	34	33	34

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	1	0	2	55	0	0	0	0	0	0	0	52.34	0	0	11.4	0.3	3.6
2025	4	1	0	12	55	0	0	0	0	0	0	0	52.29	0	0	11.4	0.3	3.6
2025	4	1	0	22	55	0	0	0	0	0	0	0	52.21	0	0	11.4	0.3	3.6
2025	4	1	0	32	55	0	0	0	0	0	0	0	52.16	0	0	11.4	0.3	3.6
2025	4	1	0	42	55	0	0	0	0	0	0	0	52.11	0	0	11.4	0.3	3.6
2025	4	1	0	52	55	0	0	0	0	0	0	0	52.07	0	0	11.4	0.3	3.6
2025	4	1	1	2	55	0	0	0	0	0	0	0	52.02	0	0	11.4	0.3	3.6
2025	4	1	1	12	55	0	0	0	0	0	0	0	51.98	0	0	11.4	0.3	3.6
2025	4	1	1	22	55	0	0	0	0	0	0	0	51.93	0	0	11.4	0.3	3.6
2025	4	1	1	32	55	0	0	0	0	0	0	0	51.87	0	0	11.4	0.3	3.6
2025	4	1	1	42	55	0	0	0	0	0	0	0	51.84	0	0	11.4	0.3	3.6
2025	4	1	1	52	55	0	0	0	0	0	0	0	51.8	0	0	11.4	0.3	3.6
2025	4	1	2	2	55	0	0	0	0	0	0	0	51.76	0	0	11.4	0.3	3.6
2025	4	1	2	12	55	0	0	0	0	0	0	0	51.73	0	0	11.4	0.3	3.6
2025	4	1	2	22	55	0	0	0	0	0	0	0	51.67	0	0	11.4	0.3	3.6
2025	4	1	2	32	55	0	0	0	0	0	0	0	51.66	0	0	11.4	0.3	3.6
2025	4	1	2	42	55	0	0	0	0	0	0	0	51.6	0	0	11.4	0.3	3.6
2025	4	1	2	52	55	0	0	0	0	0	0	0	51.57	0	0	11.4	0.3	3.6
2025	4	1	3	2	55	0	0	0	0	0	0	0	51.51	0	0	11.4	0.3	3.6
2025	4	1	3	12	55	0	0	0	0	0	0	0	51.48	0	0	11.4	0.3	3.6
2025	4	1	3	22	55	0	0	0	0	0	0	0	51.44	0	0	11.4	0.3	3.6
2025	4	1	3	32	55	0	0	0	0	0	0	0	51.42	0	0	11.4	0.3	3.6
2025	4	1	3	42	55	0	0	0	0	0	0	0	51.37	0	0	11.4	0.3	3.6
2025	4	1	3	52	55	0	0	0	0	0	0	0	51.31	0	0	11.4	0.3	3.6
2025	4	1	4	2	55	0	0	0	0	0	0	0	51.28	0	0	11.4	0.3	3.6
2025	4	1	4	12	55	0	0	0	0	0	0	0	51.24	0	0	11.4	0.3	3.6
2025	4	1	4	22	55	0	0	0	0	0	0	0	51.21	0	0	11.4	0.3	3.6
2025	4	1	4	32	55	0	0	0	0	0	0	0	51.15	0	0	11.4	0.3	3.6
2025	4	1	4	42	55	0	0	0	0	0	0	0	51.1	0	0	11.4	0.3	3.6
2025	4	1	4	52	55	0	0	0	0	0	0	0	51.04	0	0	11.4	0.3	3.6
2025	4	1	5	2	55	0	0	0	0	0	0	0	50.99	0	0	11.4	0.3	3.6
2025	4	1	5	12	55	0	0	0	0	0	0	0	50.95	0	0	11.4	0.3	3.6
2025	4	1	5	22	55	0	0	0	0	0	0	0	50.92	0	0	11.4	0.3	3.6
2025	4	1	5	32	55	0	0	0	0	0	0	0	50.86	0	0	11.4	0.3	3.6
2025	4	1	5	42	55	0	0	0	0	0	0	0	50.81	0	0	11.4	0.3	3.6
2025	4	1	5	52	55	0	0	0	0	0	0	0	50.76	0	0	11.4	0.3	3.6
2025	4	1	6	2	55	0	0	0	0	0	0	0	50.72	0	0	11.4	0.3	3.6
2025	4	1	6	12	55	0	0	0	0	0	0	0	50.68	0	0	11.4	0.3	3.6
2025	4	1	6	22	55	0	0	0	0	0	0	0	50.65	0	0	11.4	0.3	3.6
2025	4	1	6	32	55	0	0	0	0	0	0	0	50.61	0	0	11.6	0.3	3.6
2025	4	1	6	42	55	0	0	0	0	0	0	0	50.58	0	0	11.8	0.3	3.6
2025	4	1	6	52	55	0	0	0	0	0	0	0	50.54	0	0	12.2	0.3	3.6
2025	4	1	7	2	55	0	0	0	0	0	0	0	50.54	0	0	12.4	0.3	3.6
2025	4	1	7	12	55	0	0	0	0	0	0	0	50.52	0	0	12.6	0.3	3.6
2025	4	1	7	22	55	0	0	0	0	0	0	0	50.52	0	0	12.6	0.3	3.6
2025	4	1	7	32	55	0	0	0	0	0	0	0	50.52	0	0	12.6	0.3	3.6
2025	4	1	7	42	55	0	0	0	0	0	0	0	50.58	0	0	12.2	0.3	3.6
2025	4	1	7	52	55	0	0	0	0	0	0	0	50.63	0	0	12	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	1	8	2	55	0	0	0	0	0	0	0	50.67	0	0	12.2	0.3	3.6
2025	4	1	8	12	55	0	0	0	0	0	0	0	50.72	0	0	12	0.3	3.6
2025	4	1	8	22	55	0	0	0	0	0	0	0	50.77	0	0	11.8	0.3	3.6
2025	4	1	8	32	55	0	0	0	0	0	0	0	50.83	0	0	12	0.3	3.6
2025	4	1	8	42	55	0	0	0	0	0	0	0	50.88	0	0	12.4	0.3	3.6
2025	4	1	8	52	55	0	0	0	0	0	0	0	50.92	0	0	12.6	0.3	3.6
2025	4	1	9	2	55	0	0	0	0	0	0	0	50.99	0	0	12.8	0.3	3.6
2025	4	1	9	12	55	0	0	0	0	0	0	0	51.06	0	0	12.8	0.3	3.6
2025	4	1	9	22	55	0	0	0	0	0	0	0	51.13	0	0	12.8	0.3	3.6
2025	4	1	9	32	55	0	0	0	0	0	0	0	51.19	0	0	12.8	0.3	3.6
2025	4	1	9	42	55	0	0	0	0	0	0	0	51.26	0	0	12.8	0.3	3.6
2025	4	1	9	52	55	0	0	0	0	0	0	0	51.33	0	0	12.6	0.3	3.6
2025	4	1	10	2	55	0	0	0	0	0	0	0	51.37	0	0	12.6	0.3	3.6
2025	4	1	10	12	55	0	0	0	0	0	0	0	51.44	0	0	12.8	0.3	3.6
2025	4	1	10	22	55	0	0	0	0	0	0	0	51.51	0	0	13.2	0.3	3.6
2025	4	1	10	32	55	0	0	0	0	0	0	0	51.58	0	0	13.2	0.3	3.6
2025	4	1	10	42	55	0	0	0	0	0	0	0	51.66	0	0	13	0.3	3.6
2025	4	1	10	52	55	0	0	0	0	0	0	0	51.73	0	0	13	0.3	3.6
2025	4	1	11	2	55	0	0	0	0	0	0	0	51.76	0	0	13	0.3	3.6
2025	4	1	11	12	55	0	0	0	0	0	0	0	51.8	0	0	12.8	0.3	3.6
2025	4	1	11	22	55	0	0	0	0	0	0	0	51.89	0	0	13.2	0.3	3.6
2025	4	1	11	32	55	0	0	0	0	0	0	0	51.94	0	0	12.8	0.3	3.6
2025	4	1	11	42	55	0	0	0	0	0	0	0	51.85	0	0	13.2	0.3	3.6
2025	4	1	11	52	55	0	0	0	0	0	0	0	51.82	0	0	13.2	0.3	3.6
2025	4	1	12	2	55	0	0	0	0	0	0	0	51.82	0	0	13.4	0.3	3.6
2025	4	1	12	12	55	0	0	0	0	0	0	0	52.05	0	0	13.2	0.3	3.6
2025	4	1	12	22	55	0	0	0	0	0	0	0	52.16	0	0	13	0.3	3.6
2025	4	1	12	32	55	0	0	0	0	0	0	0	52.18	0	0	13.4	0.3	3.6
2025	4	1	12	42	55	0	0	0	0	0	0	0	52.14	0	0	13.6	0.3	3.6
2025	4	1	12	52	55	0	0	0	0	0	0	0	52.2	0	0	13.4	0.3	3.6
2025	4	1	13	2	55	0	0	0	0	0	0	0	52.27	0	0	13.2	0.3	3.6
2025	4	1	13	12	55	0	0	0	0	0	0	0	52.47	0	0	13.2	0.3	3.6
2025	4	1	13	22	55	0	0	0	0	0	0	0	52.57	0	0	13.4	0.3	3.6
2025	4	1	13	32	55	0	0	0	0	0	0	0	52.63	0	0	13.4	0.3	3.6
2025	4	1	13	42	55	0	0	0	0	0	0	0	52.66	0	0	13.2	0.3	3.6
2025	4	1	13	52	55	0	0	0	0	0	0	0	52.74	0	0	13.2	0.3	3.6
2025	4	1	14	2	55	0	0	0	0	0	0	0	52.77	0	0	13	0.3	3.6
2025	4	1	14	12	55	0	0	0	0	0	0	0	52.79	0	0	13	0.3	3.6
2025	4	1	14	22	55	0	0	0	0	0	0	0	52.83	0	0	12.8	0.3	3.6
2025	4	1	14	32	55	0	0	0	0	0	0	0	52.86	0	0	12.8	0.3	3.6
2025	4	1	14	42	55	0	0	0	0	0	0	0	52.84	0	0	12.8	0.3	3.6
2025	4	1	14	52	55	0	0	0	0	0	0	0	52.83	0	0	12.6	0.3	3.6
2025	4	1	15	2	55	0	0	0	0	0	0	0	52.84	0	0	12.6	0.3	3.6
2025	4	1	15	12	55	0	0	0	0	0	0	0	52.86	0	0	12.8	0.3	3.6
2025	4	1	15	22	55	0	0	0	0	0	0	0	52.86	0	0	12.8	0.3	3.6
2025	4	1	15	32	55	0	0	0	0	0	0	0	52.86	0	0	12.8	0.3	3.6
2025	4	1	15	42	55	0	0	0	0	0	0	0	52.84	0	0	12.4	0.3	3.6
2025	4	1	15	52	55	0	0	0	0	0	0	0	52.81	0	0	12.8	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	1	16	2	55	0	0	0	0	0	0	0	52.74	0	0	11.2	0.3	3.6
2025	4	1	16	12	55	0	0	0	0	0	0	0	52.7	0	0	10.8	0.3	3.6
2025	4	1	16	22	55	0	0	0	0	0	0	0	52.66	0	0	10.8	0.3	3.6
2025	4	1	16	32	55	0	0	0	0	0	0	0	52.63	0	0	10.6	0.3	3.6
2025	4	1	16	42	55	0	0	0	0	0	0	0	52.61	0	0	10.4	0.3	3.6
2025	4	1	16	52	55	0	0	0	0	0	0	0	52.57	0	0	10.6	0.3	3.6
2025	4	1	17	2	55	0	0	0	0	0	0	0	52.56	0	0	10.4	0.3	3.6
2025	4	1	17	12	55	0	0	0	0	0	0	0	52.54	0	0	10.4	0.3	3.6
2025	4	1	17	22	55	0	0	0	0	0	0	0	52.5	0	0	10.4	0.3	3.6
2025	4	1	17	32	55	0	0	0	0	0	0	0	52.48	0	0	10.4	0.3	3.6
2025	4	1	17	42	55	0	0	0	0	0	0	0	52.48	0	0	10.4	0.3	3.6
2025	4	1	17	52	55	0	0	0	0	0	0	0	52.47	0	0	10.2	0.3	3.6
2025	4	1	18	2	55	0	0	0	0	0	0	0	52.43	0	0	10.2	0.3	3.6
2025	4	1	18	12	55	0	0	0	0	0	0	0	52.39	0	0	10.2	0.3	3.6
2025	4	1	18	22	55	0	0	0	0	0	0	0	52.38	0	0	10.4	0.3	3.6
2025	4	1	18	32	55	0	0	0	0	0	0	0	52.34	0	0	10.2	0.3	3.6
2025	4	1	18	42	55	0	0	0	0	0	0	0	52.3	0	0	10.2	0.3	3.6
2025	4	1	18	52	55	0	0	0	0	0	0	0	52.25	0	0	10.2	0.3	3.6
2025	4	1	19	2	55	0	0	0	0	0	0	0	52.21	0	0	10.2	0.3	3.6
2025	4	1	19	12	55	0	0	0	0	0	0	0	52.16	0	0	10.2	0.3	3.6
2025	4	1	19	22	55	0	0	0	0	0	0	0	52.11	0	0	10.2	0.3	3.6
2025	4	1	19	32	55	0	0	0	0	0	0	0	52.05	0	0	10.4	0.3	3.6
2025	4	1	19	42	55	0	0	0	0	0	0	0	52	0	0	10.4	0.3	3.6
2025	4	1	19	52	55	0	0	0	0	0	0	0	51.93	0	0	10.4	0.3	3.6
2025	4	1	20	2	55	0	0	0	0	0	0	0	51.85	0	0	10.2	0.3	3.6
2025	4	1	20	12	55	0	0	0	0	0	0	0	51.8	0	0	10.2	0.3	3.6
2025	4	1	20	22	55	0	0	0	0	0	0	0	51.73	0	0	10.4	0.3	3.6
2025	4	1	20	32	55	0	0	0	0	0	0	0	51.67	0	0	10.2	0.3	3.6
2025	4	1	20	42	55	0	0	0	0	0	0	0	51.58	0	0	10.2	0.3	3.6
2025	4	1	20	52	55	0	0	0	0	0	0	0	51.53	0	0	10.6	0.3	3.6
2025	4	1	21	2	55	0	0	0	0	0	0	0	51.44	0	0	10.6	0.3	3.6
2025	4	1	21	12	55	0	0	0	0	0	0	0	51.37	0	0	10.4	0.3	3.6
2025	4	1	21	22	55	0	0	0	0	0	0	0	51.3	0	0	10.6	0.3	3.6
2025	4	1	21	32	55	0	0	0	0	0	0	0	51.21	0	0	10.6	0.3	3.6
2025	4	1	21	42	55	0	0	0	0	0	0	0	51.13	0	0	10.6	0.3	3.6
2025	4	1	21	52	55	0	0	0	0	0	0	0	51.04	0	0	10.6	0.3	3.6
2025	4	1	22	2	55	0	0	0	0	0	0	0	50.97	0	0	10.4	0.3	3.6
2025	4	1	22	12	55	0	0	0	0	0	0	0	50.88	0	0	9.8	0.3	3.6
2025	4	1	22	22	55	0	0	0	0	0	0	0	50.81	0	0	10.8	0.3	3.6
2025	4	1	22	32	55	0	0	0	0	0	0	0	50.74	0	0	11	0.3	3.6
2025	4	1	22	42	55	0	0	0	0	0	0	0	50.67	0	0	11.2	0.3	3.6
2025	4	1	22	52	55	0	0	0	0	0	0	0	50.58	0	0	10.8	0.3	3.6
2025	4	1	23	2	55	0	0	0	0	0	0	0	50.49	0	0	10.8	0.3	3.6
2025	4	1	23	12	55	0	0	0	0	0	0	0	50.43	0	0	11	0.3	3.6
2025	4	1	23	22	55	0	0	0	0	0	0	0	50.36	0	0	11	0.3	3.6
2025	4	1	23	32	55	0	0	0	0	0	0	0	50.29	0	0	11	0.3	3.6
2025	4	1	23	42	55	0	0	0	0	0	0	0	50.23	0	0	10.8	0.3	3.6
2025	4	1	23	52	55	0	0	0	0	0	0	0	50.16	0	0	10.8	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	2	0	2	55	0	0	0	0	0	0	0	50.09	0	0	10.6	0.3	3.6
2025	4	2	0	12	55	0	0	0	0	0	0	0	50.04	0	0	10.4	0.3	3.6
2025	4	2	0	22	55	0	0	0	0	0	0	0	49.98	0	0	10.6	0.3	3.6
2025	4	2	0	32	55	0	0	0	0	0	0	0	49.91	0	0	10.6	0.3	3.6
2025	4	2	0	42	55	0	0	0	0	0	0	0	49.86	0	0	10.4	0.3	3.6
2025	4	2	0	52	55	0	0	0	0	0	0	0	49.82	0	0	10.2	0.3	3.6
2025	4	2	1	2	55	0	0	0	0	0	0	0	49.77	0	0	10.4	0.3	3.6
2025	4	2	1	12	55	0	0	0	0	0	0	0	49.71	0	0	10.2	0.3	3.6
2025	4	2	1	22	55	0	0	0	0	0	0	0	49.68	0	0	10.2	0.3	3.6
2025	4	2	1	32	55	0	0	0	0	0	0	0	49.64	0	0	10.2	0.3	3.6
2025	4	2	1	42	55	0	0	0	0	0	0	0	49.6	0	0	10.2	0.3	3.6
2025	4	2	1	52	55	0	0	0	0	0	0	0	49.57	0	0	10	0.3	3.6
2025	4	2	2	2	55	0	0	0	0	0	0	0	49.55	0	0	10.2	0.3	3.6
2025	4	2	2	12	55	0	0	0	0	0	0	0	49.51	0	0	10.2	0.3	3.6
2025	4	2	2	22	55	0	0	0	0	0	0	0	49.5	0	0	10.6	0.3	3.6
2025	4	2	2	32	55	0	0	0	0	0	0	0	49.48	0	0	10.6	0.3	3.6
2025	4	2	2	42	55	0	0	0	0	0	0	0	49.46	0	0	10.6	0.3	3.6
2025	4	2	2	52	55	0	0	0	0	0	0	0	49.42	0	0	10.4	0.3	3.6
2025	4	2	3	2	55	0	0	0	0	0	0	0	49.42	0	0	10.4	0.3	3.6
2025	4	2	3	12	55	0	0	0	0	0	0	0	49.39	0	0	10.2	0.3	3.6
2025	4	2	3	22	55	0	0	0	0	0	0	0	49.37	0	0	11.4	0.3	3.6
2025	4	2	3	32	55	0	0	0	0	0	0	0	49.35	0	0	11.4	0.3	3.6
2025	4	2	3	42	55	0	0	0	0	0	0	0	49.33	0	0	11.4	0.3	3.6
2025	4	2	3	52	55	0	0	0	0	0	0	0	49.32	0	0	11.4	0.3	3.6
2025	4	2	4	2	55	0	0	0	0	0	0	0	49.3	0	0	11.4	0.3	3.6
2025	4	2	4	12	55	0	0	0	0	0	0	0	49.28	0	0	11.4	0.3	3.6
2025	4	2	4	22	55	0	0	0	0	0	0	0	49.26	0	0	11.4	0.3	3.6
2025	4	2	4	32	55	0	0	0	0	0	0	0	49.24	0	0	11.4	0.3	3.6
2025	4	2	4	42	55	0	0	0	0	0	0	0	49.24	0	0	11.4	0.3	3.6
2025	4	2	4	52	55	0	0	0	0	0	0	0	49.23	0	0	11.4	0.3	3.6
2025	4	2	5	2	55	0	0	0	0	0	0	0	49.21	0	0	11.4	0.3	3.6
2025	4	2	5	12	55	0	0	0	0	0	0	0	49.21	0	0	11.4	0.3	3.6
2025	4	2	5	22	55	0	0	0	0	0	0	0	49.21	0	0	11.4	0.3	3.6
2025	4	2	5	32	55	0	0	0	0	0	0	0	49.21	0	0	11.4	0.3	3.6
2025	4	2	5	42	55	0	0	0	0	0	0	0	49.23	0	0	11.4	0.3	3.6
2025	4	2	5	52	55	0	0	0	0	0	0	0	49.24	0	0	11.4	0.3	3.6
2025	4	2	6	2	55	0	0	0	0	0	0	0	49.24	0	0	11.4	0.3	3.6
2025	4	2	6	12	55	0	0	0	0	0	0	0	49.26	0	0	11.4	0.3	3.6
2025	4	2	6	22	55	0	0	0	0	0	0	0	49.3	0	0	11.6	0.3	3.6
2025	4	2	6	32	55	0	0	0	0	0	0	0	49.32	0	0	11.8	0.3	3.6
2025	4	2	6	42	55	0	0	0	0	0	0	0	49.33	0	0	11.8	0.3	3.6
2025	4	2	6	52	55	0	0	0	0	0	0	0	49.35	0	0	12	0.3	3.6
2025	4	2	7	2	55	0	0	0	0	0	0	0	49.39	0	0	12.2	0.3	3.6
2025	4	2	7	12	55	0	0	0	0	0	0	0	49.42	0	0	12.4	0.3	3.6
2025	4	2	7	22	55	0	0	0	0	0	0	0	49.48	0	0	12.6	0.3	3.6
2025	4	2	7	32	55	0	0	0	0	0	0	0	49.5	0	0	12.6	0.3	3.6
2025	4	2	7	42	55	0	0	0	0	0	0	0	49.55	0	0	12.6	0.3	3.6
2025	4	2	7	52	55	0	0	0	0	0	0	0	49.64	0	0	12.8	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	2	8	2	55	0	0	0	0	0	0	0	49.71	0	0	12.8	0.3	3.6
2025	4	2	8	12	55	0	0	0	0	0	0	0	49.75	0	0	13	0.3	3.6
2025	4	2	8	22	55	0	0	0	0	0	0	0	49.84	0	0	13	0.3	3.6
2025	4	2	8	32	55	0	0	0	0	0	0	0	49.91	0	0	13.6	0.3	3.6
2025	4	2	8	42	55	0	0	0	0	0	0	0	49.96	0	0	13.8	0.3	3.6
2025	4	2	8	52	55	0	0	0	0	0	0	0	50.04	0	0	14	0.3	3.6
2025	4	2	9	2	55	0	0	0	0	0	0	0	50.13	0	0	14.2	0.3	3.6
2025	4	2	9	12	55	0	0	0	0	0	0	0	50.18	0	0	14.2	0.3	3.6
2025	4	2	9	22	55	0	0	0	0	0	0	0	50.25	0	0	14.2	0.3	3.6
2025	4	2	9	32	55	0	0	0	0	0	0	0	50.36	0	0	14.2	0.3	3.6
2025	4	2	9	42	55	0	0	0	0	0	0	0	50.43	0	0	14	0.3	3.6
2025	4	2	9	52	55	0	0	0	0	0	0	0	50.52	0	0	14	0.3	3.6
2025	4	2	10	2	55	0	0	0	0	0	0	0	50.63	0	0	13.6	0.3	3.6
2025	4	2	10	12	55	0	0	0	0	0	0	0	50.7	0	0	13.6	0.3	3.6
2025	4	2	10	22	55	0	0	0	0	0	0	0	50.81	0	0	13.4	0.3	3.6
2025	4	2	10	32	55	0	0	0	0	0	0	0	50.9	0	0	13.4	0.3	3.6
2025	4	2	10	42	55	0	0	0	0	0	0	0	51.01	0	0	13.6	0.3	3.6
2025	4	2	10	52	55	0	0	0	0	0	0	0	51.08	0	0	13.6	0.3	3.6
2025	4	2	11	2	55	0	0	0	0	0	0	0	51.17	0	0	13.6	0.3	3.6
2025	4	2	11	12	55	0	0	0	0	0	0	0	51.24	0	0	13.6	0.3	3.6
2025	4	2	11	22	55	0	0	0	0	0	0	0	51.35	0	0	13.6	0.3	3.6
2025	4	2	11	32	55	0	0	0	0	0	0	0	51.31	0	0	13.4	0.3	3.6
2025	4	2	11	42	55	0	0	0	0	0	0	0	51.28	0	0	13.2	0.3	3.6
2025	4	2	11	52	55	0	0	0	0	0	0	0	51.21	0	0	13.2	0.3	3.6
2025	4	2	12	2	55	0	0	0	0	0	0	0	51.49	0	0	13.2	0.3	3.6
2025	4	2	12	12	55	0	0	0	0	0	0	0	51.58	0	0	13.2	0.3	3.6
2025	4	2	12	22	55	0	0	0	0	0	0	0	51.66	0	0	13.4	0.3	3.6
2025	4	2	12	32	55	0	0	0	0	0	0	0	51.6	0	0	13.2	0.3	3.6
2025	4	2	12	42	55	0	0	0	0	0	0	0	51.57	0	0	13.2	0.3	3.6
2025	4	2	12	52	55	0	0	0	0	0	0	0	51.51	0	0	13	0.3	3.6
2025	4	2	13	2	55	0	0	0	0	0	0	0	51.53	0	0	12.8	0.3	3.6
2025	4	2	13	12	55	0	0	0	0	0	0	0	51.78	0	0	13.2	0.3	3.6
2025	4	2	13	22	55	0	0	0	0	0	0	0	51.84	0	0	13.2	0.3	3.6
2025	4	2	13	32	55	0	0	0	0	0	0	0	51.8	0	0	13	0.3	3.6
2025	4	2	13	42	55	0	0	0	0	0	0	0	51.8	0	0	13	0.3	3.6
2025	4	2	13	52	55	0	0	0	0	0	0	0	51.93	0	0	13.4	0.3	3.6
2025	4	2	14	2	55	0	0	0	0	0	0	0	52.12	0	0	13.6	0.3	3.6
2025	4	2	14	12	55	0	0	0	0	0	0	0	52.05	0	0	13.6	0.3	3.6
2025	4	2	14	22	55	0	0	0	0	0	0	0	52.25	0	0	13.6	0.3	3.6
2025	4	2	14	32	55	0	0	0	0	0	0	0	52.25	0	0	13.6	0.3	3.6
2025	4	2	14	42	55	0	0	0	0	0	0	0	52.16	0	0	13.2	0.3	3.6
2025	4	2	14	52	55	0	0	0	0	0	0	0	52.11	0	0	13	0.3	3.6
2025	4	2	15	2	55	0	0	0	0	0	0	0	52.12	0	0	13	0.3	3.6
2025	4	2	15	12	55	0	0	0	0	0	0	0	52.16	0	0	13	0.3	3.6
2025	4	2	15	22	55	0	0	0	0	0	0	0	52.11	0	0	13	0.3	3.6
2025	4	2	15	32	55	0	0	0	0	0	0	0	52.03	0	0	11.6	0.3	3.6
2025	4	2	15	42	55	0	0	0	0	0	0	0	52.02	0	0	11.2	0.3	3.6
2025	4	2	15	52	55	0	0	0	0	0	0	0	51.98	0	0	11	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	2	16	2	55	0	0	0	0	0	0	0	52.02	0	0	11.8	0.3	3.6
2025	4	2	16	12	55	0	0	0	0	0	0	0	52.03	0	0	12.4	0.3	3.6
2025	4	2	16	22	55	0	0	0	0	0	0	0	52.05	0	0	11.6	0.3	3.6
2025	4	2	16	32	55	0	0	0	0	0	0	0	52.03	0	0	11	0.3	3.6
2025	4	2	16	42	55	0	0	0	0	0	0	0	52.03	0	0	11	0.3	3.6
2025	4	2	16	52	55	0	0	0	0	0	0	0	52.05	0	0	11	0.3	3.6
2025	4	2	17	2	55	0	0	0	0	0	0	0	52.07	0	0	12.2	0.3	3.6
2025	4	2	17	12	55	0	0	0	0	0	0	0	52.07	0	0	12	0.3	3.6
2025	4	2	17	22	55	0	0	0	0	0	0	0	52.07	0	0	11.6	0.3	3.6
2025	4	2	17	32	55	0	0	0	0	0	0	0	52.03	0	0	11.2	0.3	3.6
2025	4	2	17	42	55	0	0	0	0	0	0	0	52	0	0	11.2	0.3	3.6
2025	4	2	17	52	55	0	0	0	0	0	0	0	51.96	0	0	10.8	0.3	3.6
2025	4	2	18	2	55	0	0	0	0	0	0	0	51.93	0	0	10.6	0.3	3.6
2025	4	2	18	12	55	0	0	0	0	0	0	0	51.89	0	0	10.4	0.3	3.6
2025	4	2	18	22	55	0	0	0	0	0	0	0	51.84	0	0	11.2	0.3	3.6
2025	4	2	18	32	55	0	0	0	0	0	0	0	51.78	0	0	10.4	0.3	3.6
2025	4	2	18	42	55	0	0	0	0	0	0	0	51.73	0	0	10.4	0.3	3.6
2025	4	2	18	52	55	0	0	0	0	0	0	0	51.66	0	0	10.2	0.3	3.6
2025	4	2	19	2	55	0	0	0	0	0	0	0	51.6	0	0	10.2	0.3	3.6
2025	4	2	19	12	55	0	0	0	0	0	0	0	51.55	0	0	10.2	0.3	3.6
2025	4	2	19	22	55	0	0	0	0	0	0	0	51.46	0	0	10.2	0.3	3.6
2025	4	2	19	32	55	0	0	0	0	0	0	0	51.39	0	0	10.8	0.3	3.6
2025	4	2	19	42	55	0	0	0	0	0	0	0	51.31	0	0	11	0.3	3.6
2025	4	2	19	52	55	0	0	0	0	0	0	0	51.24	0	0	10.6	0.3	3.6
2025	4	2	20	2	55	0	0	0	0	0	0	0	51.19	0	0	10.6	0.3	3.6
2025	4	2	20	12	55	0	0	0	0	0	0	0	51.1	0	0	10.4	0.3	3.6
2025	4	2	20	22	55	0	0	0	0	0	0	0	51.03	0	0	10.2	0.3	3.6
2025	4	2	20	32	55	0	0	0	0	0	0	0	50.94	0	0	10.2	0.3	3.6
2025	4	2	20	42	55	0	0	0	0	0	0	0	50.86	0	0	10.2	0.3	3.6
2025	4	2	20	52	55	0	0	0	0	0	0	0	50.79	0	0	10.2	0.3	3.6
2025	4	2	21	2	55	0	0	0	0	0	0	0	50.7	0	0	10	0.3	3.6
2025	4	2	21	12	55	0	0	0	0	0	0	0	50.61	0	0	10	0.3	3.6
2025	4	2	21	22	55	0	0	0	0	0	0	0	50.54	0	0	10.4	0.3	3.6
2025	4	2	21	32	55	0	0	0	0	0	0	0	50.45	0	0	11	0.3	3.6
2025	4	2	21	42	55	0	0	0	0	0	0	0	50.38	0	0	10.8	0.3	3.6
2025	4	2	21	52	55	0	0	0	0	0	0	0	50.29	0	0	10.8	0.3	3.6
2025	4	2	22	2	55	0	0	0	0	0	0	0	50.2	0	0	11	0.3	3.6
2025	4	2	22	12	55	0	0	0	0	0	0	0	50.13	0	0	11	0.3	3.6
2025	4	2	22	22	55	0	0	0	0	0	0	0	50.04	0	0	10.8	0.3	3.6
2025	4	2	22	32	55	0	0	0	0	0	0	0	49.95	0	0	10.6	0.3	3.6
2025	4	2	22	42	55	0	0	0	0	0	0	0	49.86	0	0	10.4	0.3	3.6
2025	4	2	22	52	55	0	0	0	0	0	0	0	49.77	0	0	10.2	0.3	3.6
2025	4	2	23	2	55	0	0	0	0	0	0	0	49.68	0	0	10.2	0.3	3.6
2025	4	2	23	12	55	0	0	0	0	0	0	0	49.6	0	0	10.8	0.3	3.6
2025	4	2	23	22	55	0	0	0	0	0	0	0	49.51	0	0	10.6	0.3	3.6
2025	4	2	23	32	55	0	0	0	0	0	0	0	49.42	0	0	10.4	0.3	3.6
2025	4	2	23	42	55	0	0	0	0	0	0	0	49.33	0	0	10.4	0.3	3.6
2025	4	2	23	52	55	0	0	0	0	0	0	0	49.26	0	0	10.4	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	3	0	2	55	0	0	0	0	0	0	0	49.17	0	0	10.4	0.3	3.6
2025	4	3	0	12	55	0	0	0	0	0	0	0	49.1	0	0	10.4	0.3	3.6
2025	4	3	0	22	55	0	0	0	0	0	0	0	49.03	0	0	10.4	0.3	3.6
2025	4	3	0	32	55	0	0	0	0	0	0	0	48.96	0	0	10.4	0.3	3.6
2025	4	3	0	42	55	0	0	0	0	0	0	0	48.88	0	0	10.4	0.3	3.6
2025	4	3	0	52	55	0	0	0	0	0	0	0	48.83	0	0	10.2	0.3	3.6
2025	4	3	1	2	55	0	0	0	0	0	0	0	48.74	0	0	10.2	0.3	3.6
2025	4	3	1	12	55	0	0	0	0	0	0	0	48.69	0	0	10.2	0.3	3.6
2025	4	3	1	22	55	0	0	0	0	0	0	0	48.63	0	0	10.2	0.3	3.6
2025	4	3	1	32	55	0	0	0	0	0	0	0	48.58	0	0	10.2	0.3	3.6
2025	4	3	1	42	55	0	0	0	0	0	0	0	48.52	0	0	10.2	0.3	3.6
2025	4	3	1	52	55	0	0	0	0	0	0	0	48.47	0	0	10.2	0.3	3.6
2025	4	3	2	2	55	0	0	0	0	0	0	0	48.42	0	0	10	0.3	3.6
2025	4	3	2	12	55	0	0	0	0	0	0	0	48.38	0	0	10.6	0.3	3.6
2025	4	3	2	22	55	0	0	0	0	0	0	0	48.34	0	0	10.8	0.3	3.6
2025	4	3	2	32	55	0	0	0	0	0	0	0	48.31	0	0	10.4	0.3	3.6
2025	4	3	2	42	55	0	0	0	0	0	0	0	48.27	0	0	10.2	0.3	3.6
2025	4	3	2	52	55	0	0	0	0	0	0	0	48.25	0	0	10.2	0.3	3.6
2025	4	3	3	2	55	0	0	0	0	0	0	0	48.22	0	0	10.2	0.3	3.6
2025	4	3	3	12	55	0	0	0	0	0	0	0	48.18	0	0	10.2	0.3	3.6
2025	4	3	3	22	55	0	0	0	0	0	0	0	48.16	0	0	10.2	0.3	3.6
2025	4	3	3	32	55	0	0	0	0	0	0	0	48.13	0	0	10.2	0.3	3.6
2025	4	3	3	42	55	0	0	0	0	0	0	0	48.11	0	0	10.2	0.3	3.6
2025	4	3	3	52	55	0	0	0	0	0	0	0	48.09	0	0	10.2	0.3	3.6
2025	4	3	4	2	55	0	0	0	0	0	0	0	48.06	0	0	10	0.3	3.6
2025	4	3	4	12	55	0	0	0	0	0	0	0	48.04	0	0	10	0.3	3.6
2025	4	3	4	22	55	0	0	0	0	0	0	0	48.02	0	0	10	0.3	3.6
2025	4	3	4	32	55	0	0	0	0	0	0	0	48	0	0	10	0.3	3.6
2025	4	3	4	42	55	0	0	0	0	0	0	0	47.98	0	0	10	0.3	3.6
2025	4	3	4	52	55	0	0	0	0	0	0	0	47.97	0	0	10	0.3	3.6
2025	4	3	5	2	55	0	0	0	0	0	0	0	47.95	0	0	10	0.3	3.6
2025	4	3	5	12	55	0	0	0	0	0	0	0	47.93	0	0	9.8	0.3	3.6
2025	4	3	5	22	55	0	0	0	0	0	0	0	47.89	0	0	9.8	0.3	3.6
2025	4	3	5	32	55	0	0	0	0	0	0	0	47.89	0	0	9.8	0.3	3.6
2025	4	3	5	42	55	0	0	0	0	0	0	0	47.88	0	0	9.6	0.3	3.6
2025	4	3	5	52	55	0	0	0	0	0	0	0	47.88	0	0	9.6	0.3	3.6
2025	4	3	6	2	55	0	0	0	0	0	0	0	47.86	0	0	10	0.3	3.6
2025	4	3	6	12	55	0	0	0	0	0	0	0	47.84	0	0	10	0.3	3.6
2025	4	3	6	22	55	0	0	0	0	0	0	0	47.84	0	0	10.6	0.3	3.6
2025	4	3	6	32	55	0	0	0	0	0	0	0	47.84	0	0	11.8	0.3	3.6
2025	4	3	6	42	55	0	0	0	0	0	0	0	47.84	0	0	11.4	0.3	3.6
2025	4	3	6	52	55	0	0	0	0	0	0	0	47.86	0	0	11.6	0.3	3.6
2025	4	3	7	2	55	0	0	0	0	0	0	0	47.89	0	0	11.8	0.3	3.6
2025	4	3	7	12	55	0	0	0	0	0	0	0	47.93	0	0	12	0.3	3.6
2025	4	3	7	22	55	0	0	0	0	0	0	0	48	0	0	12.2	0.3	3.6
2025	4	3	7	32	55	0	0	0	0	0	0	0	48.02	0	0	12.2	0.3	3.6
2025	4	3	7	42	55	0	0	0	0	0	0	0	48.13	0	0	12.4	0.3	3.6
2025	4	3	7	52	55	0	0	0	0	0	0	0	48.22	0	0	12.4	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	3	8	2	55	0	0	0	0	0	0	0	48.29	0	0	12.8	0.3	3.6
2025	4	3	8	12	55	0	0	0	0	0	0	0	48.38	0	0	13	0.3	3.6
2025	4	3	8	22	55	0	0	0	0	0	0	0	48.43	0	0	13.2	0.3	3.6
2025	4	3	8	32	55	0	0	0	0	0	0	0	48.54	0	0	13.6	0.3	3.6
2025	4	3	8	42	55	0	0	0	0	0	0	0	48.63	0	0	13.6	0.3	3.6
2025	4	3	8	52	55	0	0	0	0	0	0	0	48.72	0	0	13.4	0.3	3.6
2025	4	3	9	2	55	0	0	0	0	0	0	0	48.81	0	0	13.2	0.3	3.6
2025	4	3	9	12	55	0	0	0	0	0	0	0	48.92	0	0	13.2	0.3	3.6
2025	4	3	9	22	55	0	0	0	0	0	0	0	49.01	0	0	13	0.3	3.6
2025	4	3	9	32	55	0	0	0	0	0	0	0	49.1	0	0	13	0.3	3.6
2025	4	3	9	42	55	0	0	0	0	0	0	0	49.21	0	0	13	0.3	3.6
2025	4	3	9	52	55	0	0	0	0	0	0	0	49.28	0	0	13	0.3	3.6
2025	4	3	10	2	55	0	0	0	0	0	0	0	49.39	0	0	13.6	0.3	3.6
2025	4	3	10	12	55	0	0	0	0	0	0	0	49.44	0	0	13.4	0.3	3.6
2025	4	3	10	22	55	0	0	0	0	0	0	0	49.53	0	0	13.6	0.3	3.6
2025	4	3	10	32	55	0	0	0	0	0	0	0	49.62	0	0	13.6	0.3	3.6
2025	4	3	10	42	55	0	0	0	0	0	0	0	49.73	0	0	13.4	0.3	3.6
2025	4	3	10	52	55	0	0	0	0	0	0	0	49.82	0	0	13.6	0.3	3.6
2025	4	3	11	2	55	0	0	0	0	0	0	0	49.93	0	0	13.4	0.3	3.6
2025	4	3	11	12	55	0	0	0	0	0	0	0	50.02	0	0	13.2	0.3	3.6
2025	4	3	11	22	55	0	0	0	0	0	0	0	50.11	0	0	12.8	0.3	3.6
2025	4	3	11	32	55	0	0	0	0	0	0	0	50.22	0	0	12.4	0.3	3.6
2025	4	3	11	42	55	0	0	0	0	0	0	0	50.31	0	0	12.2	0.3	3.6
2025	4	3	11	52	55	0	0	0	0	0	0	0	50.4	0	0	13.2	0.3	3.6
2025	4	3	12	2	55	0	0	0	0	0	0	0	50.47	0	0	13	0.3	3.6
2025	4	3	12	12	55	0	0	0	0	0	0	0	50.56	0	0	13.2	0.3	3.6
2025	4	3	12	22	55	0	0	0	0	0	0	0	50.65	0	0	12.8	0.3	3.6
2025	4	3	12	32	55	0	0	0	0	0	0	0	50.72	0	0	12.8	0.3	3.6
2025	4	3	12	42	55	0	0	0	0	0	0	0	50.81	0	0	12.4	0.3	3.6
2025	4	3	12	52	55	0	0	0	0	0	0	0	50.85	0	0	12.8	0.3	3.6
2025	4	3	13	2	55	0	0	0	0	0	0	0	50.94	0	0	12.8	0.3	3.6
2025	4	3	13	12	55	0	0	0	0	0	0	0	50.99	0	0	13	0.3	3.6
2025	4	3	13	22	55	0	0	0	0	0	0	0	51.06	0	0	13.6	0.3	3.6
2025	4	3	13	32	55	0	0	0	0	0	0	0	51.1	0	0	13.4	0.3	3.6
2025	4	3	13	42	55	0	0	0	0	0	0	0	51.19	0	0	13.4	0.3	3.6
2025	4	3	13	52	55	0	0	0	0	0	0	0	51.26	0	0	13.2	0.3	3.6
2025	4	3	14	2	55	0	0	0	0	0	0	0	51.31	0	0	13.4	0.3	3.6
2025	4	3	14	12	55	0	0	0	0	0	0	0	51.33	0	0	13.4	0.3	3.6
2025	4	3	14	22	55	0	0	0	0	0	0	0	51.37	0	0	13.4	0.3	3.6
2025	4	3	14	32	55	0	0	0	0	0	0	0	51.42	0	0	13.2	0.3	3.6
2025	4	3	14	42	55	0	0	0	0	0	0	0	51.46	0	0	13	0.3	3.6
2025	4	3	14	52	55	0	0	0	0	0	0	0	51.44	0	0	13.2	0.3	3.6
2025	4	3	15	2	55	0	0	0	0	0	0	0	51.49	0	0	13.2	0.3	3.6
2025	4	3	15	12	55	0	0	0	0	0	0	0	51.53	0	0	13.2	0.3	3.6
2025	4	3	15	22	55	0	0	0	0	0	0	0	51.42	0	0	11.4	0.3	3.6
2025	4	3	15	32	55	0	0	0	0	0	0	0	51.51	0	0	13	0.3	3.6
2025	4	3	15	42	55	0	0	0	0	0	0	0	51.55	0	0	12.8	0.3	3.6
2025	4	3	15	52	55	0	0	0	0	0	0	0	51.57	0	0	12.6	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	3	16	2	55	0	0	0	0	0	0	0	51.58	0	0	12.4	0.3	3.6
2025	4	3	16	12	55	0	0	0	0	0	0	0	51.57	0	0	11.6	0.3	3.6
2025	4	3	16	22	55	0	0	0	0	0	0	0	51.6	0	0	11.6	0.3	3.6
2025	4	3	16	32	55	0	0	0	0	0	0	0	51.58	0	0	10.8	0.3	3.6
2025	4	3	16	42	55	0	0	0	0	0	0	0	51.57	0	0	10.8	0.3	3.6
2025	4	3	16	52	55	0	0	0	0	0	0	0	51.55	0	0	10.6	0.3	3.6
2025	4	3	17	2	55	0	0	0	0	0	0	0	51.53	0	0	10.2	0.3	3.6
2025	4	3	17	12	55	0	0	0	0	0	0	0	51.51	0	0	10.2	0.3	3.6
2025	4	3	17	22	55	0	0	0	0	0	0	0	51.49	0	0	10	0.3	3.6
2025	4	3	17	32	55	0	0	0	0	0	0	0	51.48	0	0	10	0.3	3.6
2025	4	3	17	42	55	0	0	0	0	0	0	0	51.48	0	0	9.8	0.3	3.6
2025	4	3	17	52	55	0	0	0	0	0	0	0	51.46	0	0	10.4	0.3	3.6
2025	4	3	18	2	55	0	0	0	0	0	0	0	51.44	0	0	11.2	0.3	3.6
2025	4	3	18	12	55	0	0	0	0	0	0	0	51.4	0	0	10.6	0.3	3.6
2025	4	3	18	22	55	0	0	0	0	0	0	0	51.39	0	0	10.8	0.3	3.6
2025	4	3	18	32	55	0	0	0	0	0	0	0	51.35	0	0	11	0.3	3.6
2025	4	3	18	42	55	0	0	0	0	0	0	0	51.31	0	0	11	0.3	3.6
2025	4	3	18	52	55	0	0	0	0	0	0	0	51.28	0	0	11	0.3	3.6
2025	4	3	19	2	55	0	0	0	0	0	0	0	51.24	0	0	11	0.3	3.6
2025	4	3	19	12	55	0	0	0	0	0	0	0	51.19	0	0	11	0.3	3.6
2025	4	3	19	22	55	0	0	0	0	0	0	0	51.13	0	0	11	0.3	3.6
2025	4	3	19	32	55	0	0	0	0	0	0	0	51.06	0	0	11	0.3	3.6
2025	4	3	19	42	55	0	0	0	0	0	0	0	51.01	0	0	11	0.3	3.6
2025	4	3	19	52	55	0	0	0	0	0	0	0	50.94	0	0	11	0.3	3.6
2025	4	3	20	2	55	0	0	0	0	0	0	0	50.88	0	0	11	0.3	3.6
2025	4	3	20	12	55	0	0	0	0	0	0	0	50.79	0	0	11	0.3	3.6
2025	4	3	20	22	55	0	0	0	0	0	0	0	50.74	0	0	11	0.3	3.6
2025	4	3	20	32	55	0	0	0	0	0	0	0	50.67	0	0	11	0.3	3.6
2025	4	3	20	42	55	0	0	0	0	0	0	0	50.58	0	0	11	0.3	3.6
2025	4	3	20	52	55	0	0	0	0	0	0	0	50.5	0	0	11	0.3	3.6
2025	4	3	21	2	55	0	0	0	0	0	0	0	50.41	0	0	11	0.3	3.6
2025	4	3	21	12	55	0	0	0	0	0	0	0	50.32	0	0	11	0.3	3.6
2025	4	3	21	22	55	0	0	0	0	0	0	0	50.23	0	0	11	0.3	3.6
2025	4	3	21	32	55	0	0	0	0	0	0	0	50.14	0	0	11	0.3	3.6
2025	4	3	21	42	55	0	0	0	0	0	0	0	50.05	0	0	11	0.3	3.6
2025	4	3	21	52	55	0	0	0	0	0	0	0	49.96	0	0	11	0.3	3.6
2025	4	3	22	2	55	0	0	0	0	0	0	0	49.87	0	0	11	0.3	3.6
2025	4	3	22	12	55	0	0	0	0	0	0	0	49.78	0	0	11	0.3	3.6
2025	4	3	22	22	55	0	0	0	0	0	0	0	49.69	0	0	11	0.3	3.6
2025	4	3	22	32	55	0	0	0	0	0	0	0	49.59	0	0	11	0.3	3.6
2025	4	3	22	42	55	0	0	0	0	0	0	0	49.51	0	0	11	0.3	3.6
2025	4	3	22	52	55	0	0	0	0	0	0	0	49.41	0	0	11	0.3	3.6
2025	4	3	23	2	55	0	0	0	0	0	0	0	49.32	0	0	11	0.3	3.6
2025	4	3	23	12	55	0	0	0	0	0	0	0	49.23	0	0	11	0.3	3.6
2025	4	3	23	22	55	0	0	0	0	0	0	0	49.15	0	0	11	0.3	3.6
2025	4	3	23	32	55	0	0	0	0	0	0	0	49.06	0	0	11	0.3	3.6
2025	4	3	23	42	55	0	0	0	0	0	0	0	48.99	0	0	11	0.3	3.6
2025	4	3	23	52	55	0	0	0	0	0	0	0	48.92	0	0	11	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	4	0	2	55	0	0	0	0	0	0	0	48.85	0	0	11	0.3	3.6
2025	4	4	0	12	55	0	0	0	0	0	0	0	48.78	0	0	11	0.3	3.6
2025	4	4	0	22	55	0	0	0	0	0	0	0	48.7	0	0	11	0.3	3.6
2025	4	4	0	32	55	0	0	0	0	0	0	0	48.63	0	0	11	0.3	3.6
2025	4	4	0	42	55	0	0	0	0	0	0	0	48.58	0	0	11	0.3	3.6
2025	4	4	0	52	55	0	0	0	0	0	0	0	48.52	0	0	11	0.3	3.6
2025	4	4	1	2	55	0	0	0	0	0	0	0	48.47	0	0	11	0.3	3.6
2025	4	4	1	12	55	0	0	0	0	0	0	0	48.42	0	0	11	0.3	3.6
2025	4	4	1	22	55	0	0	0	0	0	0	0	48.38	0	0	11	0.3	3.6
2025	4	4	1	32	55	0	0	0	0	0	0	0	48.33	0	0	11	0.3	3.6
2025	4	4	1	42	55	0	0	0	0	0	0	0	48.27	0	0	11	0.3	3.6
2025	4	4	1	52	55	0	0	0	0	0	0	0	48.24	0	0	11	0.3	3.6
2025	4	4	2	2	55	0	0	0	0	0	0	0	48.18	0	0	11	0.3	3.6
2025	4	4	2	12	55	0	0	0	0	0	0	0	48.15	0	0	11	0.3	3.6
2025	4	4	2	22	55	0	0	0	0	0	0	0	48.11	0	0	11	0.3	3.6
2025	4	4	2	32	55	0	0	0	0	0	0	0	48.07	0	0	11	0.3	3.6
2025	4	4	2	42	55	0	0	0	0	0	0	0	48.04	0	0	11	0.3	3.6
2025	4	4	2	52	55	0	0	0	0	0	0	0	48.02	0	0	11	0.3	3.6
2025	4	4	3	2	55	0	0	0	0	0	0	0	48	0	0	10.8	0.3	3.6
2025	4	4	3	12	55	0	0	0	0	0	0	0	48	0	0	11	0.3	3.6
2025	4	4	3	22	55	0	0	0	0	0	0	0	47.98	0	0	11	0.3	3.6
2025	4	4	3	32	55	0	0	0	0	0	0	0	47.98	0	0	11	0.3	3.6
2025	4	4	3	42	55	0	0	0	0	0	0	0	47.97	0	0	10.8	0.3	3.6
2025	4	4	3	52	55	0	0	0	0	0	0	0	47.95	0	0	11	0.3	3.6
2025	4	4	4	2	55	0	0	0	0	0	0	0	47.95	0	0	11	0.3	3.6
2025	4	4	4	12	55	0	0	0	0	0	0	0	47.93	0	0	11	0.3	3.6
2025	4	4	4	22	55	0	0	0	0	0	0	0	47.93	0	0	11	0.3	3.6
2025	4	4	4	32	55	0	0	0	0	0	0	0	47.93	0	0	11	0.3	3.6
2025	4	4	4	42	55	0	0	0	0	0	0	0	47.93	0	0	11	0.3	3.6
2025	4	4	4	52	55	0	0	0	0	0	0	0	47.95	0	0	10.8	0.3	3.6
2025	4	4	5	2	55	0	0	0	0	0	0	0	47.95	0	0	11	0.3	3.6
2025	4	4	5	12	55	0	0	0	0	0	0	0	47.95	0	0	11	0.3	3.6
2025	4	4	5	22	55	0	0	0	0	0	0	0	47.97	0	0	11	0.3	3.6
2025	4	4	5	32	55	0	0	0	0	0	0	0	47.97	0	0	11	0.3	3.6
2025	4	4	5	42	55	0	0	0	0	0	0	0	47.98	0	0	11	0.3	3.6
2025	4	4	5	52	55	0	0	0	0	0	0	0	48	0	0	10.8	0.3	3.6
2025	4	4	6	2	55	0	0	0	0	0	0	0	48.02	0	0	11	0.3	3.6
2025	4	4	6	12	55	0	0	0	0	0	0	0	48.02	0	0	11	0.3	3.6
2025	4	4	6	22	55	0	0	0	0	0	0	0	48.04	0	0	11	0.3	3.6
2025	4	4	6	32	55	0	0	0	0	0	0	0	48.07	0	0	11.2	0.3	3.6
2025	4	4	6	42	55	0	0	0	0	0	0	0	48.09	0	0	11.4	0.3	3.6
2025	4	4	6	52	55	0	0	0	0	0	0	0	48.11	0	0	11.6	0.3	3.6
2025	4	4	7	2	55	0	0	0	0	0	0	0	48.16	0	0	11.8	0.3	3.6
2025	4	4	7	12	55	0	0	0	0	0	0	0	48.22	0	0	12	0.3	3.6
2025	4	4	7	22	55	0	0	0	0	0	0	0	48.29	0	0	12.2	0.3	3.6
2025	4	4	7	32	55	0	0	0	0	0	0	0	48.34	0	0	12.4	0.3	3.6
2025	4	4	7	42	55	0	0	0	0	0	0	0	48.43	0	0	12.4	0.3	3.6
2025	4	4	7	52	55	0	0	0	0	0	0	0	48.54	0	0	12.4	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	4	8	2	55	0	0	0	0	0	0	0	48.63	0	0	12.4	0.3	3.6
2025	4	4	8	12	55	0	0	0	0	0	0	0	48.72	0	0	12.6	0.3	3.6
2025	4	4	8	22	55	0	0	0	0	0	0	0	48.81	0	0	12.8	0.3	3.6
2025	4	4	8	32	55	0	0	0	0	0	0	0	48.88	0	0	12.6	0.3	3.6
2025	4	4	8	42	55	0	0	0	0	0	0	0	48.97	0	0	12.8	0.3	3.6
2025	4	4	8	52	55	0	0	0	0	0	0	0	49.06	0	0	13.2	0.3	3.6
2025	4	4	9	2	55	0	0	0	0	0	0	0	49.17	0	0	13	0.3	3.6
2025	4	4	9	12	55	0	0	0	0	0	0	0	49.26	0	0	13	0.3	3.6
2025	4	4	9	22	55	0	0	0	0	0	0	0	49.39	0	0	13.2	0.3	3.6
2025	4	4	9	32	55	0	0	0	0	0	0	0	49.46	0	0	13.4	0.3	3.6
2025	4	4	9	42	55	0	0	0	0	0	0	0	49.55	0	0	13.2	0.3	3.6
2025	4	4	9	52	55	0	0	0	0	0	0	0	49.64	0	0	12.8	0.3	3.6
2025	4	4	10	2	55	0	0	0	0	0	0	0	49.78	0	0	12.4	0.3	3.6
2025	4	4	10	12	55	0	0	0	0	0	0	0	49.71	0	0	12	0.3	3.6
2025	4	4	10	22	55	0	0	0	0	0	0	0	49.73	0	0	11.8	0.3	3.6
2025	4	4	10	32	55	0	0	0	0	0	0	0	49.66	0	0	12.2	0.3	3.6
2025	4	4	10	42	55	0	0	0	0	0	0	0	49.75	0	0	13	0.3	3.6
2025	4	4	10	52	55	0	0	0	0	0	0	0	49.8	0	0	13	0.3	3.6
2025	4	4	11	2	55	0	0	0	0	0	0	0	49.78	0	0	13	0.3	3.6
2025	4	4	11	12	55	0	0	0	0	0	0	0	49.98	0	0	13	0.3	3.6
2025	4	4	11	22	55	0	0	0	0	0	0	0	49.91	0	0	13	0.3	3.6
2025	4	4	11	32	55	0	0	0	0	0	0	0	50.07	0	0	13	0.3	3.6
2025	4	4	11	42	55	0	0	0	0	0	0	0	50.18	0	0	13	0.3	3.6
2025	4	4	11	52	55	0	0	0	0	0	0	0	50.23	0	0	12.8	0.3	3.6
2025	4	4	12	2	55	0	0	0	0	0	0	0	50.4	0	0	13	0.3	3.6
2025	4	4	12	12	55	0	0	0	0	0	0	0	50.52	0	0	12.8	0.3	3.6
2025	4	4	12	22	55	0	0	0	0	0	0	0	50.76	0	0	12.8	0.3	3.6
2025	4	4	12	32	55	0	0	0	0	0	0	0	50.94	0	0	12.8	0.3	3.6
2025	4	4	12	42	55	0	0	0	0	0	0	0	50.9	0	0	12.8	0.3	3.6
2025	4	4	12	52	55	0	0	0	0	0	0	0	51.1	0	0	12.8	0.3	3.6
2025	4	4	13	2	55	0	0	0	0	0	0	0	51.24	0	0	12.8	0.3	3.6
2025	4	4	13	12	55	0	0	0	0	0	0	0	51.03	0	0	12.6	0.3	3.6
2025	4	4	13	22	55	0	0	0	0	0	0	0	51.19	0	0	12.8	0.3	3.6
2025	4	4	13	32	55	0	0	0	0	0	0	0	51.22	0	0	12.8	0.3	3.6
2025	4	4	13	42	55	0	0	0	0	0	0	0	51.28	0	0	13	0.3	3.6
2025	4	4	13	52	55	0	0	0	0	0	0	0	51.28	0	0	13	0.3	3.6
2025	4	4	14	2	55	0	0	0	0	0	0	0	51.26	0	0	12.6	0.3	3.6
2025	4	4	14	12	55	0	0	0	0	0	0	0	51.3	0	0	12.4	0.3	3.6
2025	4	4	14	22	55	0	0	0	0	0	0	0	51.31	0	0	12.6	0.3	3.6
2025	4	4	14	32	55	0	0	0	0	0	0	0	51.53	0	0	12.8	0.3	3.6
2025	4	4	14	42	55	0	0	0	0	0	0	0	51.57	0	0	12.8	0.3	3.6
2025	4	4	14	52	55	0	0	0	0	0	0	0	51.48	0	0	11.4	0.3	3.6
2025	4	4	15	2	55	0	0	0	0	0	0	0	51.66	0	0	12.8	0.3	3.6
2025	4	4	15	12	55	0	0	0	0	0	0	0	51.66	0	0	12.6	0.3	3.6
2025	4	4	15	22	55	0	0	0	0	0	0	0	51.64	0	0	13.2	0.3	3.6
2025	4	4	15	32	55	0	0	0	0	0	0	0	51.71	0	0	12.8	0.3	3.6
2025	4	4	15	42	55	0	0	0	0	0	0	0	51.76	0	0	13.2	0.3	3.6
2025	4	4	15	52	55	0	0	0	0	0	0	0	51.73	0	0	11.2	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	4	16	2	55	0	0	0	0	0	0	0	51.76	0	0	11	0.3	3.6
2025	4	4	16	12	55	0	0	0	0	0	0	0	51.78	0	0	10.8	0.3	3.6
2025	4	4	16	22	55	0	0	0	0	0	0	0	51.82	0	0	10.8	0.3	3.6
2025	4	4	16	32	55	0	0	0	0	0	0	0	51.84	0	0	12	0.3	3.6
2025	4	4	16	42	55	0	0	0	0	0	0	0	51.8	0	0	11.6	0.3	3.6
2025	4	4	16	52	55	0	0	0	0	0	0	0	51.78	0	0	11.4	0.3	3.6
2025	4	4	17	2	55	0	0	0	0	0	0	0	51.76	0	0	11.2	0.3	3.6
2025	4	4	17	12	55	0	0	0	0	0	0	0	51.75	0	0	10.8	0.3	3.6
2025	4	4	17	22	55	0	0	0	0	0	0	0	51.75	0	0	10.6	0.3	3.6
2025	4	4	17	32	55	0	0	0	0	0	0	0	51.75	0	0	10.2	0.3	3.6
2025	4	4	17	42	55	0	0	0	0	0	0	0	51.73	0	0	9.6	0.3	3.6
2025	4	4	17	52	55	0	0	0	0	0	0	0	51.69	0	0	9.2	0.3	3.6
2025	4	4	18	2	55	0	0	0	0	0	0	0	51.67	0	0	11.4	0.3	3.6
2025	4	4	18	12	55	0	0	0	0	0	0	0	51.66	0	0	11.6	0.3	3.6
2025	4	4	18	22	55	0	0	0	0	0	0	0	51.64	0	0	11.6	0.3	3.6
2025	4	4	18	32	55	0	0	0	0	0	0	0	51.62	0	0	11.6	0.3	3.6
2025	4	4	18	42	55	0	0	0	0	0	0	0	51.58	0	0	11.6	0.3	3.6
2025	4	4	18	52	55	0	0	0	0	0	0	0	51.55	0	0	11.4	0.3	3.6
2025	4	4	19	2	55	0	0	0	0	0	0	0	51.51	0	0	11.4	0.3	3.6
2025	4	4	19	12	55	0	0	0	0	0	0	0	51.48	0	0	11.4	0.3	3.6
2025	4	4	19	22	55	0	0	0	0	0	0	0	51.44	0	0	11.4	0.3	3.6
2025	4	4	19	32	55	0	0	0	0	0	0	0	51.39	0	0	11.4	0.3	3.6
2025	4	4	19	42	55	0	0	0	0	0	0	0	51.33	0	0	11.4	0.3	3.6
2025	4	4	19	52	55	0	0	0	0	0	0	0	51.28	0	0	11.4	0.3	3.6
2025	4	4	20	2	55	0	0	0	0	0	0	0	51.24	0	0	11.4	0.3	3.6
2025	4	4	20	12	55	0	0	0	0	0	0	0	51.17	0	0	11.4	0.3	3.6
2025	4	4	20	22	55	0	0	0	0	0	0	0	51.1	0	0	11.4	0.3	3.6
2025	4	4	20	32	55	0	0	0	0	0	0	0	51.03	0	0	11.4	0.3	3.6
2025	4	4	20	42	55	0	0	0	0	0	0	0	50.94	0	0	11.4	0.3	3.6
2025	4	4	20	52	55	0	0	0	0	0	0	0	50.86	0	0	11.4	0.3	3.6
2025	4	4	21	2	55	0	0	0	0	0	0	0	50.77	0	0	11.4	0.3	3.6
2025	4	4	21	12	55	0	0	0	0	0	0	0	50.68	0	0	11.4	0.3	3.6
2025	4	4	21	22	55	0	0	0	0	0	0	0	50.59	0	0	11.4	0.3	3.6
2025	4	4	21	32	55	0	0	0	0	0	0	0	50.5	0	0	11.4	0.3	3.6
2025	4	4	21	42	55	0	0	0	0	0	0	0	50.43	0	0	11.4	0.3	3.6
2025	4	4	21	52	55	0	0	0	0	0	0	0	50.32	0	0	11.4	0.3	3.6
2025	4	4	22	2	55	0	0	0	0	0	0	0	50.23	0	0	11.4	0.3	3.6
2025	4	4	22	12	55	0	0	0	0	0	0	0	50.16	0	0	11.4	0.3	3.6
2025	4	4	22	22	55	0	0	0	0	0	0	0	50.07	0	0	11.4	0.3	3.6
2025	4	4	22	32	55	0	0	0	0	0	0	0	49.98	0	0	11.4	0.3	3.6
2025	4	4	22	42	55	0	0	0	0	0	0	0	49.89	0	0	11.4	0.3	3.6
2025	4	4	22	52	55	0	0	0	0	0	0	0	49.8	0	0	11.4	0.3	3.6
2025	4	4	23	2	55	0	0	0	0	0	0	0	49.73	0	0	11.4	0.3	3.6
2025	4	4	23	12	55	0	0	0	0	0	0	0	49.64	0	0	11.4	0.3	3.6
2025	4	4	23	22	55	0	0	0	0	0	0	0	49.55	0	0	11.4	0.3	3.6
2025	4	4	23	32	55	0	0	0	0	0	0	0	49.46	0	0	11.4	0.3	3.6
2025	4	4	23	42	55	0	0	0	0	0	0	0	49.41	0	0	11.4	0.3	3.6
2025	4	4	23	52	55	0	0	0	0	0	0	0	49.32	0	0	11.4	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	5	0	2	55	0	0	0	0	0	0	0	49.23	0	0	11.4	0.3	3.6
2025	4	5	0	12	55	0	0	0	0	0	0	0	49.15	0	0	11.4	0.3	3.6
2025	4	5	0	22	55	0	0	0	0	0	0	0	49.06	0	0	11.4	0.3	3.6
2025	4	5	0	32	55	0	0	0	0	0	0	0	48.99	0	0	11.4	0.3	3.6
2025	4	5	0	42	55	0	0	0	0	0	0	0	48.92	0	0	11.4	0.3	3.6
2025	4	5	0	52	55	0	0	0	0	0	0	0	48.85	0	0	11.4	0.3	3.6
2025	4	5	1	2	55	0	0	0	0	0	0	0	48.79	0	0	11.4	0.3	3.6
2025	4	5	1	12	55	0	0	0	0	0	0	0	48.72	0	0	11.2	0.3	3.6
2025	4	5	1	22	55	0	0	0	0	0	0	0	48.65	0	0	11.2	0.3	3.6
2025	4	5	1	32	55	0	0	0	0	0	0	0	48.6	0	0	11.2	0.3	3.6
2025	4	5	1	42	55	0	0	0	0	0	0	0	48.54	0	0	11.2	0.3	3.6
2025	4	5	1	52	55	0	0	0	0	0	0	0	48.49	0	0	11.2	0.3	3.6
2025	4	5	2	2	55	0	0	0	0	0	0	0	48.42	0	0	11.2	0.3	3.6
2025	4	5	2	12	55	0	0	0	0	0	0	0	48.36	0	0	11.2	0.3	3.6
2025	4	5	2	22	55	0	0	0	0	0	0	0	48.33	0	0	11.2	0.3	3.6
2025	4	5	2	32	55	0	0	0	0	0	0	0	48.29	0	0	11.2	0.3	3.6
2025	4	5	2	42	55	0	0	0	0	0	0	0	48.24	0	0	11.2	0.3	3.6
2025	4	5	2	52	55	0	0	0	0	0	0	0	48.2	0	0	11.2	0.3	3.6
2025	4	5	3	2	55	0	0	0	0	0	0	0	48.15	0	0	11.2	0.3	3.6
2025	4	5	3	12	55	0	0	0	0	0	0	0	48.11	0	0	11.2	0.3	3.6
2025	4	5	3	22	55	0	0	0	0	0	0	0	48.09	0	0	11.2	0.3	3.6
2025	4	5	3	32	55	0	0	0	0	0	0	0	48.07	0	0	11.2	0.3	3.6
2025	4	5	3	42	55	0	0	0	0	0	0	0	48.04	0	0	11.2	0.3	3.6
2025	4	5	3	52	55	0	0	0	0	0	0	0	48.02	0	0	11.2	0.3	3.6
2025	4	5	4	2	55	0	0	0	0	0	0	0	48	0	0	11.2	0.3	3.6
2025	4	5	4	12	55	0	0	0	0	0	0	0	47.98	0	0	11.2	0.3	3.6
2025	4	5	4	22	55	0	0	0	0	0	0	0	47.97	0	0	11.2	0.3	3.6
2025	4	5	4	32	55	0	0	0	0	0	0	0	47.95	0	0	11.2	0.3	3.6
2025	4	5	4	42	55	0	0	0	0	0	0	0	47.95	0	0	11.2	0.3	3.6
2025	4	5	4	52	55	0	0	0	0	0	0	0	47.95	0	0	11.2	0.3	3.6
2025	4	5	5	2	55	0	0	0	0	0	0	0	47.95	0	0	11.2	0.3	3.6
2025	4	5	5	12	55	0	0	0	0	0	0	0	47.95	0	0	11.2	0.3	3.6
2025	4	5	5	22	55	0	0	0	0	0	0	0	47.95	0	0	11.2	0.3	3.6
2025	4	5	5	32	55	0	0	0	0	0	0	0	47.93	0	0	11.2	0.3	3.6
2025	4	5	5	42	55	0	0	0	0	0	0	0	47.93	0	0	11.2	0.3	3.6
2025	4	5	5	52	55	0	0	0	0	0	0	0	47.93	0	0	11.2	0.3	3.6
2025	4	5	6	2	55	0	0	0	0	0	0	0	47.95	0	0	11.2	0.3	3.6
2025	4	5	6	12	55	0	0	0	0	0	0	0	47.95	0	0	11.2	0.3	3.6
2025	4	5	6	22	55	0	0	0	0	0	0	0	47.97	0	0	11.4	0.3	3.6
2025	4	5	6	32	55	0	0	0	0	0	0	0	47.98	0	0	11.6	0.3	3.6
2025	4	5	6	42	55	0	0	0	0	0	0	0	48	0	0	11.8	0.3	3.6
2025	4	5	6	52	55	0	0	0	0	0	0	0	48.04	0	0	12	0.3	3.6
2025	4	5	7	2	55	0	0	0	0	0	0	0	48.07	0	0	12.2	0.3	3.6
2025	4	5	7	12	55	0	0	0	0	0	0	0	48.13	0	0	12.2	0.3	3.6
2025	4	5	7	22	55	0	0	0	0	0	0	0	48.18	0	0	12.4	0.3	3.6
2025	4	5	7	32	55	0	0	0	0	0	0	0	48.25	0	0	12.4	0.3	3.6
2025	4	5	7	42	55	0	0	0	0	0	0	0	48.34	0	0	13	0.3	3.6
2025	4	5	7	52	55	0	0	0	0	0	0	0	48.43	0	0	13	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	5	8	2	55	0	0	0	0	0	0	0	48.51	0	0	13.2	0.3	3.6
2025	4	5	8	12	55	0	0	0	0	0	0	0	48.61	0	0	13.4	0.3	3.6
2025	4	5	8	22	55	0	0	0	0	0	0	0	48.7	0	0	13.4	0.3	3.6
2025	4	5	8	32	55	0	0	0	0	0	0	0	48.78	0	0	13.4	0.3	3.6
2025	4	5	8	42	55	0	0	0	0	0	0	0	48.87	0	0	13.8	0.3	3.6
2025	4	5	8	52	55	0	0	0	0	0	0	0	48.99	0	0	13.8	0.3	3.6
2025	4	5	9	2	55	0	0	0	0	0	0	0	49.06	0	0	13.8	0.3	3.6
2025	4	5	9	12	55	0	0	0	0	0	0	0	49.17	0	0	13.8	0.3	3.6
2025	4	5	9	22	55	0	0	0	0	0	0	0	49.28	0	0	13.8	0.3	3.6
2025	4	5	9	32	55	0	0	0	0	0	0	0	49.37	0	0	13.8	0.3	3.6
2025	4	5	9	42	55	0	0	0	0	0	0	0	49.48	0	0	13.8	0.3	3.6
2025	4	5	9	52	55	0	0	0	0	0	0	0	49.59	0	0	13.6	0.3	3.6
2025	4	5	10	2	55	0	0	0	0	0	0	0	49.69	0	0	13.8	0.3	3.6
2025	4	5	10	12	55	0	0	0	0	0	0	0	49.8	0	0	13.8	0.3	3.6
2025	4	5	10	22	55	0	0	0	0	0	0	0	49.91	0	0	13.8	0.3	3.6
2025	4	5	10	32	55	0	0	0	0	0	0	0	50.02	0	0	13.6	0.3	3.6
2025	4	5	10	42	55	0	0	0	0	0	0	0	50.13	0	0	13.6	0.3	3.6
2025	4	5	10	52	55	0	0	0	0	0	0	0	50.25	0	0	13.4	0.3	3.6
2025	4	5	11	2	55	0	0	0	0	0	0	0	50.36	0	0	13.4	0.3	3.6
2025	4	5	11	12	55	0	0	0	0	0	0	0	50.45	0	0	13.4	0.3	3.6
2025	4	5	11	22	55	0	0	0	0	0	0	0	50.58	0	0	13.4	0.3	3.6
2025	4	5	11	32	55	0	0	0	0	0	0	0	50.67	0	0	13.4	0.3	3.6
2025	4	5	11	42	55	0	0	0	0	0	0	0	50.77	0	0	13.4	0.3	3.6
2025	4	5	11	52	55	0	0	0	0	0	0	0	50.85	0	0	13.4	0.3	3.6
2025	4	5	12	2	55	0	0	0	0	0	0	0	50.97	0	0	13.4	0.3	3.6
2025	4	5	12	12	55	0	0	0	0	0	0	0	51.06	0	0	13.4	0.3	3.6
2025	4	5	12	22	55	0	0	0	0	0	0	0	51.17	0	0	13.8	0.3	3.6
2025	4	5	12	32	55	0	0	0	0	0	0	0	51.22	0	0	13.8	0.3	3.6
2025	4	5	12	42	55	0	0	0	0	0	0	0	51.33	0	0	13.6	0.3	3.6
2025	4	5	12	52	55	0	0	0	0	0	0	0	51.4	0	0	13.8	0.3	3.6
2025	4	5	13	2	55	0	0	0	0	0	0	0	51.49	0	0	13.8	0.3	3.6
2025	4	5	13	12	55	0	0	0	0	0	0	0	51.57	0	0	13.6	0.3	3.6
2025	4	5	13	22	55	0	0	0	0	0	0	0	51.66	0	0	13.6	0.3	3.6
2025	4	5	13	32	55	0	0	0	0	0	0	0	51.73	0	0	13.6	0.3	3.6
2025	4	5	13	42	55	0	0	0	0	0	0	0	51.8	0	0	13.6	0.3	3.6
2025	4	5	13	52	55	0	0	0	0	0	0	0	51.85	0	0	13.6	0.3	3.6
2025	4	5	14	2	55	0	0	0	0	0	0	0	51.94	0	0	13.4	0.3	3.6
2025	4	5	14	12	55	0	0	0	0	0	0	0	51.98	0	0	13.4	0.3	3.6
2025	4	5	14	22	55	0	0	0	0	0	0	0	52.05	0	0	13.4	0.3	3.6
2025	4	5	14	32	55	0	0	0	0	0	0	0	52.11	0	0	13.4	0.3	3.6
2025	4	5	14	42	55	0	0	0	0	0	0	0	52.14	0	0	13.4	0.3	3.6
2025	4	5	14	52	55	0	0	0	0	0	0	0	52.2	0	0	13.4	0.3	3.6
2025	4	5	15	2	55	0	0	0	0	0	0	0	52.23	0	0	13.2	0.3	3.6
2025	4	5	15	12	55	0	0	0	0	0	0	0	52.25	0	0	13.2	0.3	3.6
2025	4	5	15	22	55	0	0	0	0	0	0	0	52.29	0	0	13.2	0.3	3.6
2025	4	5	15	32	55	0	0	0	0	0	0	0	52.32	0	0	13.2	0.3	3.6
2025	4	5	15	42	55	0	0	0	0	0	0	0	52.34	0	0	13.2	0.3	3.6
2025	4	5	15	52	55	0	0	0	0	0	0	0	52.38	0	0	13.2	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	5	16	2	55	0	0	0	0	0	0	0	52.38	0	0	13.2	0.3	3.6
2025	4	5	16	12	55	0	0	0	0	0	0	0	52.39	0	0	13	0.3	3.6
2025	4	5	16	22	55	0	0	0	0	0	0	0	52.39	0	0	12.4	0.3	3.6
2025	4	5	16	32	55	0	0	0	0	0	0	0	52.39	0	0	12.2	0.3	3.6
2025	4	5	16	42	55	0	0	0	0	0	0	0	52.39	0	0	12.2	0.3	3.6
2025	4	5	16	52	55	0	0	0	0	0	0	0	52.38	0	0	12	0.3	3.6
2025	4	5	17	2	55	0	0	0	0	0	0	0	52.36	0	0	11.8	0.3	3.6
2025	4	5	17	12	55	0	0	0	0	0	0	0	52.34	0	0	11.8	0.3	3.6
2025	4	5	17	22	55	0	0	0	0	0	0	0	52.32	0	0	11.8	0.3	3.6
2025	4	5	17	32	55	0	0	0	0	0	0	0	52.3	0	0	11.8	0.3	3.6
2025	4	5	17	42	55	0	0	0	0	0	0	0	52.29	0	0	11.8	0.3	3.6
2025	4	5	17	52	55	0	0	0	0	0	0	0	52.25	0	0	11.8	0.3	3.6
2025	4	5	18	2	55	0	0	0	0	0	0	0	52.21	0	0	11.6	0.3	3.6
2025	4	5	18	12	55	0	0	0	0	0	0	0	52.16	0	0	11.6	0.3	3.6
2025	4	5	18	22	55	0	0	0	0	0	0	0	52.11	0	0	11.6	0.3	3.6
2025	4	5	18	32	55	0	0	0	0	0	0	0	52.05	0	0	11.6	0.3	3.6
2025	4	5	18	42	55	0	0	0	0	0	0	0	52	0	0	11.6	0.3	3.6
2025	4	5	18	52	55	0	0	0	0	0	0	0	51.93	0	0	11.6	0.3	3.6
2025	4	5	19	2	55	0	0	0	0	0	0	0	51.87	0	0	11.6	0.3	3.6
2025	4	5	19	12	55	0	0	0	0	0	0	0	51.8	0	0	11.6	0.3	3.6
2025	4	5	19	22	55	0	0	0	0	0	0	0	51.71	0	0	11.6	0.3	3.6
2025	4	5	19	32	55	0	0	0	0	0	0	0	51.64	0	0	11.6	0.3	3.6
2025	4	5	19	42	55	0	0	0	0	0	0	0	51.55	0	0	11.6	0.3	3.6
2025	4	5	19	52	55	0	0	0	0	0	0	0	51.46	0	0	11.6	0.3	3.6
2025	4	5	20	2	55	0	0	0	0	0	0	0	51.35	0	0	11.6	0.3	3.6
2025	4	5	20	12	55	0	0	0	0	0	0	0	51.26	0	0	11.6	0.3	3.6
2025	4	5	20	22	55	0	0	0	0	0	0	0	51.15	0	0	11.6	0.3	3.6
2025	4	5	20	32	55	0	0	0	0	0	0	0	51.04	0	0	11.6	0.3	3.6
2025	4	5	20	42	55	0	0	0	0	0	0	0	50.94	0	0	11.6	0.3	3.6
2025	4	5	20	52	55	0	0	0	0	0	0	0	50.85	0	0	11.6	0.3	3.6
2025	4	5	21	2	55	0	0	0	0	0	0	0	50.74	0	0	11.6	0.3	3.6
2025	4	5	21	12	55	0	0	0	0	0	0	0	50.63	0	0	11.6	0.3	3.6
2025	4	5	21	22	55	0	0	0	0	0	0	0	50.54	0	0	11.6	0.3	3.6
2025	4	5	21	32	55	0	0	0	0	0	0	0	50.43	0	0	11.6	0.3	3.6
2025	4	5	21	42	55	0	0	0	0	0	0	0	50.34	0	0	11.6	0.3	3.6
2025	4	5	21	52	55	0	0	0	0	0	0	0	50.25	0	0	11.6	0.3	3.6
2025	4	5	22	2	55	0	0	0	0	0	0	0	50.14	0	0	11.6	0.3	3.6
2025	4	5	22	12	55	0	0	0	0	0	0	0	50.05	0	0	11.6	0.3	3.6
2025	4	5	22	22	55	0	0	0	0	0	0	0	49.96	0	0	11.6	0.3	3.6
2025	4	5	22	32	55	0	0	0	0	0	0	0	49.86	0	0	11.6	0.3	3.6
2025	4	5	22	42	55	0	0	0	0	0	0	0	49.75	0	0	11.6	0.3	3.6
2025	4	5	22	52	55	0	0	0	0	0	0	0	49.66	0	0	11.6	0.3	3.6
2025	4	5	23	2	55	0	0	0	0	0	0	0	49.55	0	0	11.6	0.3	3.6
2025	4	5	23	12	55	0	0	0	0	0	0	0	49.46	0	0	11.6	0.3	3.6
2025	4	5	23	22	55	0	0	0	0	0	0	0	49.39	0	0	11.6	0.3	3.6
2025	4	5	23	32	55	0	0	0	0	0	0	0	49.3	0	0	11.6	0.3	3.6
2025	4	5	23	42	55	0	0	0	0	0	0	0	49.21	0	0	11.6	0.3	3.6
2025	4	5	23	52	55	0	0	0	0	0	0	0	49.14	0	0	11.6	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	6	0	2	55	0	0	0	0	0	0	0	49.06	0	0	11.4	0.3	3.6
2025	4	6	0	12	55	0	0	0	0	0	0	0	48.99	0	0	11.4	0.3	3.6
2025	4	6	0	22	55	0	0	0	0	0	0	0	48.94	0	0	11.4	0.3	3.6
2025	4	6	0	32	55	0	0	0	0	0	0	0	48.85	0	0	11.4	0.3	3.6
2025	4	6	0	42	55	0	0	0	0	0	0	0	48.81	0	0	11.4	0.3	3.6
2025	4	6	0	52	55	0	0	0	0	0	0	0	48.76	0	0	11.4	0.3	3.6
2025	4	6	1	2	55	0	0	0	0	0	0	0	48.7	0	0	11.4	0.3	3.6
2025	4	6	1	12	55	0	0	0	0	0	0	0	48.65	0	0	11.4	0.3	3.6
2025	4	6	1	22	55	0	0	0	0	0	0	0	48.61	0	0	11.4	0.3	3.6
2025	4	6	1	32	55	0	0	0	0	0	0	0	48.56	0	0	11.4	0.3	3.6
2025	4	6	1	42	55	0	0	0	0	0	0	0	48.52	0	0	11.4	0.3	3.6
2025	4	6	1	52	55	0	0	0	0	0	0	0	48.51	0	0	11.4	0.3	3.6
2025	4	6	2	2	55	0	0	0	0	0	0	0	48.47	0	0	11.4	0.3	3.6
2025	4	6	2	12	55	0	0	0	0	0	0	0	48.45	0	0	11.4	0.3	3.6
2025	4	6	2	22	55	0	0	0	0	0	0	0	48.43	0	0	11.4	0.3	3.6
2025	4	6	2	32	55	0	0	0	0	0	0	0	48.42	0	0	11.4	0.3	3.6
2025	4	6	2	42	55	0	0	0	0	0	0	0	48.38	0	0	11.4	0.3	3.6
2025	4	6	2	52	55	0	0	0	0	0	0	0	48.38	0	0	11.4	0.3	3.6
2025	4	6	3	2	55	0	0	0	0	0	0	0	48.38	0	0	11.4	0.3	3.6
2025	4	6	3	12	55	0	0	0	0	0	0	0	48.38	0	0	11.4	0.3	3.6
2025	4	6	3	22	55	0	0	0	0	0	0	0	48.36	0	0	11.4	0.3	3.6
2025	4	6	3	32	55	0	0	0	0	0	0	0	48.36	0	0	11.4	0.3	3.6
2025	4	6	3	42	55	0	0	0	0	0	0	0	48.34	0	0	11.4	0.3	3.6
2025	4	6	3	52	55	0	0	0	0	0	0	0	48.34	0	0	11.4	0.3	3.6
2025	4	6	4	2	55	0	0	0	0	0	0	0	48.34	0	0	11.4	0.3	3.6
2025	4	6	4	12	55	0	0	0	0	0	0	0	48.34	0	0	11.4	0.3	3.6
2025	4	6	4	22	55	0	0	0	0	0	0	0	48.36	0	0	11.4	0.3	3.6
2025	4	6	4	32	55	0	0	0	0	0	0	0	48.36	0	0	11.4	0.3	3.6
2025	4	6	4	42	55	0	0	0	0	0	0	0	48.36	0	0	11.4	0.3	3.6
2025	4	6	4	52	55	0	0	0	0	0	0	0	48.36	0	0	11.4	0.3	3.6
2025	4	6	5	2	55	0	0	0	0	0	0	0	48.36	0	0	11.4	0.3	3.6
2025	4	6	5	12	55	0	0	0	0	0	0	0	48.36	0	0	11.4	0.3	3.6
2025	4	6	5	22	55	0	0	0	0	0	0	0	48.36	0	0	11.4	0.3	3.6
2025	4	6	5	32	55	0	0	0	0	0	0	0	48.36	0	0	11.4	0.3	3.6
2025	4	6	5	42	55	0	0	0	0	0	0	0	48.36	0	0	11.4	0.3	3.6
2025	4	6	5	52	55	0	0	0	0	0	0	0	48.38	0	0	11.4	0.3	3.6
2025	4	6	6	2	55	0	0	0	0	0	0	0	48.38	0	0	11.4	0.3	3.6
2025	4	6	6	12	55	0	0	0	0	0	0	0	48.38	0	0	11.4	0.3	3.6
2025	4	6	6	22	55	0	0	0	0	0	0	0	48.38	0	0	11.6	0.3	3.6
2025	4	6	6	32	55	0	0	0	0	0	0	0	48.42	0	0	11.8	0.3	3.6
2025	4	6	6	42	55	0	0	0	0	0	0	0	48.43	0	0	12	0.3	3.6
2025	4	6	6	52	55	0	0	0	0	0	0	0	48.47	0	0	12.2	0.3	3.6
2025	4	6	7	2	55	0	0	0	0	0	0	0	48.51	0	0	12.4	0.3	3.6
2025	4	6	7	12	55	0	0	0	0	0	0	0	48.56	0	0	12.6	0.3	3.6
2025	4	6	7	22	55	0	0	0	0	0	0	0	48.63	0	0	12.6	0.3	3.6
2025	4	6	7	32	55	0	0	0	0	0	0	0	48.7	0	0	12.8	0.3	3.6
2025	4	6	7	42	55	0	0	0	0	0	0	0	48.79	0	0	12.8	0.3	3.6
2025	4	6	7	52	55	0	0	0	0	0	0	0	48.88	0	0	12.8	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	6	8	2	55	0	0	0	0	0	0	0	48.97	0	0	13	0.3	3.6
2025	4	6	8	12	55	0	0	0	0	0	0	0	49.06	0	0	13.6	0.3	3.6
2025	4	6	8	22	55	0	0	0	0	0	0	0	49.15	0	0	13.8	0.3	3.6
2025	4	6	8	32	55	0	0	0	0	0	0	0	49.28	0	0	13.8	0.3	3.6
2025	4	6	8	42	55	0	0	0	0	0	0	0	49.37	0	0	14	0.3	3.6
2025	4	6	8	52	55	0	0	0	0	0	0	0	49.48	0	0	14	0.3	3.6
2025	4	6	9	2	55	0	0	0	0	0	0	0	49.6	0	0	13.8	0.3	3.6
2025	4	6	9	12	55	0	0	0	0	0	0	0	49.71	0	0	13.2	0.3	3.6
2025	4	6	9	22	55	0	0	0	0	0	0	0	49.82	0	0	13.4	0.3	3.6
2025	4	6	9	32	55	0	0	0	0	0	0	0	49.93	0	0	13	0.3	3.6
2025	4	6	9	42	55	0	0	0	0	0	0	0	50.05	0	0	13.2	0.3	3.6
2025	4	6	9	52	55	0	0	0	0	0	0	0	50.18	0	0	13	0.3	3.6
2025	4	6	10	2	55	0	0	0	0	0	0	0	50.29	0	0	12.8	0.3	3.6
2025	4	6	10	12	55	0	0	0	0	0	0	0	50.4	0	0	12.6	0.3	3.6
2025	4	6	10	22	55	0	0	0	0	0	0	0	50.5	0	0	13.2	0.3	3.6
2025	4	6	10	32	55	0	0	0	0	0	0	0	50.63	0	0	13	0.3	3.6
2025	4	6	10	42	55	0	0	0	0	0	0	0	50.76	0	0	12.8	0.3	3.6
2025	4	6	10	52	55	0	0	0	0	0	0	0	50.86	0	0	12.8	0.3	3.6
2025	4	6	11	2	55	0	0	0	0	0	0	0	51.01	0	0	12.6	0.3	3.6
2025	4	6	11	12	55	0	0	0	0	0	0	0	51.12	0	0	12.4	0.3	3.6
2025	4	6	11	22	55	0	0	0	0	0	0	0	51.22	0	0	12.4	0.3	3.6
2025	4	6	11	32	55	0	0	0	0	0	0	0	51.35	0	0	12.4	0.3	3.6
2025	4	6	11	42	55	0	0	0	0	0	0	0	51.46	0	0	12.6	0.3	3.6
2025	4	6	11	52	55	0	0	0	0	0	0	0	51.58	0	0	12.6	0.3	3.6
2025	4	6	12	2	55	0	0	0	0	0	0	0	51.67	0	0	12.4	0.3	3.6
2025	4	6	12	12	55	0	0	0	0	0	0	0	51.78	0	0	12.4	0.3	3.6
2025	4	6	12	22	55	0	0	0	0	0	0	0	51.91	0	0	12.2	0.3	3.6
2025	4	6	12	32	55	0	0	0	0	0	0	0	52	0	0	12.2	0.3	3.6
2025	4	6	12	42	55	0	0	0	0	0	0	0	52.09	0	0	12.4	0.3	3.6
2025	4	6	12	52	55	0	0	0	0	0	0	0	52.18	0	0	12.6	0.3	3.6
2025	4	6	13	2	55	0	0	0	0	0	0	0	52.25	0	0	12.6	0.3	3.6
2025	4	6	13	12	55	0	0	0	0	0	0	0	52.36	0	0	12.4	0.3	3.6
2025	4	6	13	22	55	0	0	0	0	0	0	0	52.41	0	0	12.6	0.3	3.6
2025	4	6	13	32	55	0	0	0	0	0	0	0	52.52	0	0	12.8	0.3	3.6
2025	4	6	13	42	55	0	0	0	0	0	0	0	52.57	0	0	13	0.3	3.6
2025	4	6	13	52	55	0	0	0	0	0	0	0	52.65	0	0	12.8	0.3	3.6
2025	4	6	14	2	55	0	0	0	0	0	0	0	52.72	0	0	12.6	0.3	3.6
2025	4	6	14	12	55	0	0	0	0	0	0	0	52.77	0	0	12.8	0.3	3.6
2025	4	6	14	22	55	0	0	0	0	0	0	0	52.83	0	0	12.8	0.3	3.6
2025	4	6	14	32	55	0	0	0	0	0	0	0	52.92	0	0	12.8	0.3	3.6
2025	4	6	14	42	55	0	0	0	0	0	0	0	52.95	0	0	12.6	0.3	3.6
2025	4	6	14	52	55	0	0	0	0	0	0	0	53.01	0	0	13	0.3	3.6
2025	4	6	15	2	55	0	0	0	0	0	0	0	53.04	0	0	13	0.3	3.6
2025	4	6	15	12	55	0	0	0	0	0	0	0	53.06	0	0	12.8	0.3	3.6
2025	4	6	15	22	55	0	0	0	0	0	0	0	53.08	0	0	12.6	0.3	3.6
2025	4	6	15	32	55	0	0	0	0	0	0	0	53.11	0	0	12.6	0.3	3.6
2025	4	6	15	42	55	0	0	0	0	0	0	0	53.11	0	0	12.6	0.3	3.6
2025	4	6	15	52	55	0	0	0	0	0	0	0	53.11	0	0	12	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	6	16	2	55	0	0	0	0	0	0	0	53.08	0	0	11.8	0.3	3.6
2025	4	6	16	12	55	0	0	0	0	0	0	0	53.04	0	0	11.4	0.3	3.6
2025	4	6	16	22	55	0	0	0	0	0	0	0	53.02	0	0	11.4	0.3	3.6
2025	4	6	16	32	55	0	0	0	0	0	0	0	53.01	0	0	11.2	0.3	3.6
2025	4	6	16	42	55	0	0	0	0	0	0	0	52.99	0	0	11.2	0.3	3.6
2025	4	6	16	52	55	0	0	0	0	0	0	0	52.97	0	0	11	0.3	3.6
2025	4	6	17	2	55	0	0	0	0	0	0	0	52.95	0	0	11	0.3	3.6
2025	4	6	17	12	55	0	0	0	0	0	0	0	52.92	0	0	10.8	0.3	3.6
2025	4	6	17	22	55	0	0	0	0	0	0	0	52.9	0	0	10.8	0.3	3.6
2025	4	6	17	32	55	0	0	0	0	0	0	0	52.86	0	0	10.8	0.3	3.6
2025	4	6	17	42	55	0	0	0	0	0	0	0	52.83	0	0	10.8	0.3	3.6
2025	4	6	17	52	55	0	0	0	0	0	0	0	52.79	0	0	10.6	0.3	3.6
2025	4	6	18	2	55	0	0	0	0	0	0	0	52.74	0	0	10.6	0.3	3.6
2025	4	6	18	12	55	0	0	0	0	0	0	0	52.68	0	0	10.4	0.3	3.6
2025	4	6	18	22	55	0	0	0	0	0	0	0	52.61	0	0	10.4	0.3	3.6
2025	4	6	18	32	55	0	0	0	0	0	0	0	52.56	0	0	10.2	0.3	3.6
2025	4	6	18	42	55	0	0	0	0	0	0	0	52.47	0	0	10.2	0.3	3.6
2025	4	6	18	52	55	0	0	0	0	0	0	0	52.39	0	0	10.2	0.3	3.6
2025	4	6	19	2	55	0	0	0	0	0	0	0	52.29	0	0	10.2	0.3	3.6
2025	4	6	19	12	55	0	0	0	0	0	0	0	52.21	0	0	10.2	0.3	3.6
2025	4	6	19	22	55	0	0	0	0	0	0	0	52.12	0	0	11	0.3	3.6
2025	4	6	19	32	55	0	0	0	0	0	0	0	52.02	0	0	11	0.3	3.6
2025	4	6	19	42	55	0	0	0	0	0	0	0	51.93	0	0	11	0.3	3.6
2025	4	6	19	52	55	0	0	0	0	0	0	0	51.84	0	0	11	0.3	3.6
2025	4	6	20	2	55	0	0	0	0	0	0	0	51.73	0	0	11	0.3	3.6
2025	4	6	20	12	55	0	0	0	0	0	0	0	51.64	0	0	11	0.3	3.6
2025	4	6	20	22	55	0	0	0	0	0	0	0	51.53	0	0	11	0.3	3.6
2025	4	6	20	32	55	0	0	0	0	0	0	0	51.42	0	0	11	0.3	3.6
2025	4	6	20	42	55	0	0	0	0	0	0	0	51.33	0	0	11	0.3	3.6
2025	4	6	20	52	55	0	0	0	0	0	0	0	51.22	0	0	11	0.3	3.6
2025	4	6	21	2	55	0	0	0	0	0	0	0	51.12	0	0	11	0.3	3.6
2025	4	6	21	12	55	0	0	0	0	0	0	0	51.03	0	0	11	0.3	3.6
2025	4	6	21	22	55	0	0	0	0	0	0	0	50.94	0	0	11	0.3	3.6
2025	4	6	21	32	55	0	0	0	0	0	0	0	50.83	0	0	11	0.3	3.6
2025	4	6	21	42	55	0	0	0	0	0	0	0	50.74	0	0	11	0.3	3.6
2025	4	6	21	52	55	0	0	0	0	0	0	0	50.63	0	0	11	0.3	3.6
2025	4	6	22	2	55	0	0	0	0	0	0	0	50.52	0	0	11	0.3	3.6
2025	4	6	22	12	55	0	0	0	0	0	0	0	50.43	0	0	11	0.3	3.6
2025	4	6	22	22	55	0	0	0	0	0	0	0	50.34	0	0	11	0.3	3.6
2025	4	6	22	32	55	0	0	0	0	0	0	0	50.27	0	0	11	0.3	3.6
2025	4	6	22	42	55	0	0	0	0	0	0	0	50.18	0	0	11	0.3	3.6
2025	4	6	22	52	55	0	0	0	0	0	0	0	50.11	0	0	11	0.3	3.6
2025	4	6	23	2	55	0	0	0	0	0	0	0	50	0	0	11	0.3	3.6
2025	4	6	23	12	55	0	0	0	0	0	0	0	49.95	0	0	11	0.3	3.6
2025	4	6	23	22	55	0	0	0	0	0	0	0	49.84	0	0	10.8	0.3	3.6
2025	4	6	23	32	55	0	0	0	0	0	0	0	49.78	0	0	11	0.3	3.6
2025	4	6	23	42	55	0	0	0	0	0	0	0	49.71	0	0	11	0.3	3.6
2025	4	6	23	52	55	0	0	0	0	0	0	0	49.64	0	0	11	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	7	0	2	55	0	0	0	0	0	0	0	49.59	0	0	11	0.3	3.6
2025	4	7	0	12	55	0	0	0	0	0	0	0	49.51	0	0	11	0.3	3.6
2025	4	7	0	22	55	0	0	0	0	0	0	0	49.46	0	0	11.2	0.3	3.6
2025	4	7	0	32	55	0	0	0	0	0	0	0	49.42	0	0	11	0.3	3.6
2025	4	7	0	42	55	0	0	0	0	0	0	0	49.37	0	0	11	0.3	3.6
2025	4	7	0	52	55	0	0	0	0	0	0	0	49.33	0	0	11	0.3	3.6
2025	4	7	1	2	55	0	0	0	0	0	0	0	49.28	0	0	11	0.3	3.6
2025	4	7	1	12	55	0	0	0	0	0	0	0	49.24	0	0	11	0.3	3.6
2025	4	7	1	22	55	0	0	0	0	0	0	0	49.21	0	0	11	0.3	3.6
2025	4	7	1	32	55	0	0	0	0	0	0	0	49.19	0	0	11	0.3	3.6
2025	4	7	1	42	55	0	0	0	0	0	0	0	49.15	0	0	11	0.3	3.6
2025	4	7	1	52	55	0	0	0	0	0	0	0	49.14	0	0	11	0.3	3.6
2025	4	7	2	2	55	0	0	0	0	0	0	0	49.12	0	0	10.8	0.3	3.6
2025	4	7	2	12	55	0	0	0	0	0	0	0	49.1	0	0	10.8	0.3	3.6
2025	4	7	2	22	55	0	0	0	0	0	0	0	49.08	0	0	10.8	0.3	3.6
2025	4	7	2	32	55	0	0	0	0	0	0	0	49.08	0	0	10.8	0.3	3.6
2025	4	7	2	42	55	0	0	0	0	0	0	0	49.06	0	0	10.8	0.3	3.6
2025	4	7	2	52	55	0	0	0	0	0	0	0	49.06	0	0	10.8	0.3	3.6
2025	4	7	3	2	55	0	0	0	0	0	0	0	49.06	0	0	10.8	0.3	3.6
2025	4	7	3	12	55	0	0	0	0	0	0	0	49.06	0	0	10.8	0.3	3.6
2025	4	7	3	22	55	0	0	0	0	0	0	0	49.06	0	0	10.8	0.3	3.6
2025	4	7	3	32	55	0	0	0	0	0	0	0	49.06	0	0	10.8	0.3	3.6
2025	4	7	3	42	55	0	0	0	0	0	0	0	49.06	0	0	10.8	0.3	3.6
2025	4	7	3	52	55	0	0	0	0	0	0	0	49.08	0	0	10.8	0.3	3.6
2025	4	7	4	2	55	0	0	0	0	0	0	0	49.1	0	0	10.8	0.3	3.6
2025	4	7	4	12	55	0	0	0	0	0	0	0	49.1	0	0	10.8	0.3	3.6
2025	4	7	4	22	55	0	0	0	0	0	0	0	49.12	0	0	10.8	0.3	3.6
2025	4	7	4	32	55	0	0	0	0	0	0	0	49.14	0	0	10.8	0.3	3.6
2025	4	7	4	42	55	0	0	0	0	0	0	0	49.15	0	0	10.8	0.3	3.6
2025	4	7	4	52	55	0	0	0	0	0	0	0	49.17	0	0	10.8	0.3	3.6
2025	4	7	5	2	55	0	0	0	0	0	0	0	49.17	0	0	10.8	0.3	3.6
2025	4	7	5	12	55	0	0	0	0	0	0	0	49.21	0	0	10.8	0.3	3.6
2025	4	7	5	22	55	0	0	0	0	0	0	0	49.23	0	0	10.8	0.3	3.6
2025	4	7	5	32	55	0	0	0	0	0	0	0	49.24	0	0	10.8	0.3	3.6
2025	4	7	5	42	55	0	0	0	0	0	0	0	49.26	0	0	10.8	0.3	3.6
2025	4	7	5	52	55	0	0	0	0	0	0	0	49.28	0	0	10.8	0.3	3.6
2025	4	7	6	2	55	0	0	0	0	0	0	0	49.32	0	0	10.8	0.3	3.6
2025	4	7	6	12	55	0	0	0	0	0	0	0	49.35	0	0	10.8	0.3	3.6
2025	4	7	6	22	55	0	0	0	0	0	0	0	49.37	0	0	11	0.3	3.6
2025	4	7	6	32	55	0	0	0	0	0	0	0	49.41	0	0	11	0.3	3.6
2025	4	7	6	42	55	0	0	0	0	0	0	0	49.46	0	0	11	0.3	3.6
2025	4	7	6	52	55	0	0	0	0	0	0	0	49.5	0	0	11	0.3	3.6
2025	4	7	7	2	55	0	0	0	0	0	0	0	49.53	0	0	11	0.3	3.6
2025	4	7	7	12	55	0	0	0	0	0	0	0	49.57	0	0	11.4	0.3	3.6
2025	4	7	7	22	55	0	0	0	0	0	0	0	49.66	0	0	12	0.3	3.6
2025	4	7	7	32	55	0	0	0	0	0	0	0	49.75	0	0	12.4	0.3	3.6
2025	4	7	7	42	55	0	0	0	0	0	0	0	49.86	0	0	12.4	0.3	3.6
2025	4	7	7	52	55	0	0	0	0	0	0	0	49.95	0	0	12.4	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	7	8	2	55	0	0	0	0	0	0	0	50.04	0	0	12.6	0.3	3.6
2025	4	7	8	12	55	0	0	0	0	0	0	0	50.13	0	0	12.8	0.3	3.6
2025	4	7	8	22	55	0	0	0	0	0	0	0	50.23	0	0	12.8	0.3	3.6
2025	4	7	8	32	55	0	0	0	0	0	0	0	50.27	0	0	12.6	0.3	3.6
2025	4	7	8	42	55	0	0	0	0	0	0	0	50.36	0	0	12.6	0.3	3.6
2025	4	7	8	52	55	0	0	0	0	0	0	0	50.47	0	0	13	0.3	3.6
2025	4	7	9	2	55	0	0	0	0	0	0	0	50.61	0	0	13.2	0.3	3.6
2025	4	7	9	12	55	0	0	0	0	0	0	0	50.68	0	0	13.2	0.3	3.6
2025	4	7	9	22	55	0	0	0	0	0	0	0	50.77	0	0	13	0.3	3.6
2025	4	7	9	32	55	0	0	0	0	0	0	0	50.85	0	0	13.2	0.3	3.6
2025	4	7	9	42	55	0	0	0	0	0	0	0	50.88	0	0	12.6	0.3	3.6
2025	4	7	9	52	55	0	0	0	0	0	0	0	50.94	0	0	12.6	0.3	3.6
2025	4	7	10	2	55	0	0	0	0	0	0	0	50.99	0	0	12.4	0.3	3.6
2025	4	7	10	12	55	0	0	0	0	0	0	0	51.04	0	0	12.8	0.3	3.6
2025	4	7	10	22	55	0	0	0	0	0	0	0	51.12	0	0	12.8	0.3	3.6
2025	4	7	10	32	55	0	0	0	0	0	0	0	51.21	0	0	12.8	0.3	3.6
2025	4	7	10	42	55	0	0	0	0	0	0	0	51.26	0	0	13	0.3	3.6
2025	4	7	10	52	55	0	0	0	0	0	0	0	51.39	0	0	12.8	0.3	3.6
2025	4	7	11	2	55	0	0	0	0	0	0	0	51.55	0	0	13	0.3	3.6
2025	4	7	11	12	55	0	0	0	0	0	0	0	51.73	0	0	13	0.3	3.6
2025	4	7	11	22	55	0	0	0	0	0	0	0	51.87	0	0	13	0.3	3.6
2025	4	7	11	32	55	0	0	0	0	0	0	0	52.07	0	0	12.8	0.3	3.6
2025	4	7	11	42	55	0	0	0	0	0	0	0	52.2	0	0	12.8	0.3	3.6
2025	4	7	11	52	55	0	0	0	0	0	0	0	52.29	0	0	12.8	0.3	3.6
2025	4	7	12	2	55	0	0	0	0	0	0	0	52.47	0	0	12.8	0.3	3.6
2025	4	7	12	12	55	0	0	0	0	0	0	0	52.63	0	0	12.6	0.3	3.6
2025	4	7	12	22	55	0	0	0	0	0	0	0	52.81	0	0	12.6	0.3	3.6
2025	4	7	12	32	55	0	0	0	0	0	0	0	52.9	0	0	12.6	0.3	3.6
2025	4	7	12	42	55	0	0	0	0	0	0	0	53.02	0	0	12.6	0.3	3.6
2025	4	7	12	52	55	0	0	0	0	0	0	0	53.11	0	0	12.6	0.3	3.6
2025	4	7	13	2	55	0	0	0	0	0	0	0	53.2	0	0	12.8	0.3	3.6
2025	4	7	13	12	55	0	0	0	0	0	0	0	53.31	0	0	12.8	0.3	3.6
2025	4	7	13	22	55	0	0	0	0	0	0	0	53.44	0	0	12.6	0.3	3.6
2025	4	7	13	32	55	0	0	0	0	0	0	0	53.47	0	0	12.8	0.3	3.6
2025	4	7	13	42	55	0	0	0	0	0	0	0	53.56	0	0	12.8	0.3	3.6
2025	4	7	13	52	55	0	0	0	0	0	0	0	53.69	0	0	12.8	0.3	3.6
2025	4	7	14	2	55	0	0	0	0	0	0	0	53.8	0	0	12.6	0.3	3.6
2025	4	7	14	12	55	0	0	0	0	0	0	0	53.89	0	0	12.6	0.3	3.6
2025	4	7	14	22	55	0	0	0	0	0	0	0	53.96	0	0	12.6	0.3	3.6
2025	4	7	14	32	55	0	0	0	0	0	0	0	54.03	0	0	12.6	0.3	3.6
2025	4	7	14	42	55	0	0	0	0	0	0	0	54.09	0	0	12.6	0.3	3.6
2025	4	7	14	52	55	0	0	0	0	0	0	0	54.14	0	0	12.4	0.3	3.6
2025	4	7	15	2	55	0	0	0	0	0	0	0	54.18	0	0	12.4	0.3	3.6
2025	4	7	15	12	55	0	0	0	0	0	0	0	54.23	0	0	12.6	0.3	3.6
2025	4	7	15	22	55	0	0	0	0	0	0	0	54.25	0	0	12.4	0.3	3.6
2025	4	7	15	32	55	0	0	0	0	0	0	0	54.28	0	0	12.4	0.3	3.6
2025	4	7	15	42	55	0	0	0	0	0	0	0	54.3	0	0	12.4	0.3	3.6
2025	4	7	15	52	55	0	0	0	0	0	0	0	54.32	0	0	12.4	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	7	16	2	55	0	0	0	0	0	0	0	54.3	0	0	12.4	0.3	3.6
2025	4	7	16	12	55	0	0	0	0	0	0	0	54.34	0	0	11.6	0.3	3.6
2025	4	7	16	22	55	0	0	0	0	0	0	0	54.34	0	0	11.2	0.3	3.6
2025	4	7	16	32	55	0	0	0	0	0	0	0	54.34	0	0	11	0.3	3.6
2025	4	7	16	42	55	0	0	0	0	0	0	0	54.34	0	0	11	0.3	3.6
2025	4	7	16	52	55	0	0	0	0	0	0	0	54.3	0	0	10.8	0.3	3.6
2025	4	7	17	2	55	0	0	0	0	0	0	0	54.28	0	0	10.4	0.3	3.6
2025	4	7	17	12	55	0	0	0	0	0	0	0	54.27	0	0	10.2	0.3	3.6
2025	4	7	17	22	55	0	0	0	0	0	0	0	54.27	0	0	10.2	0.3	3.6
2025	4	7	17	32	55	0	0	0	0	0	0	0	54.25	0	0	10	0.3	3.6
2025	4	7	17	42	55	0	0	0	0	0	0	0	54.23	0	0	10	0.3	3.6
2025	4	7	17	52	55	0	0	0	0	0	0	0	54.19	0	0	10	0.3	3.6
2025	4	7	18	2	55	0	0	0	0	0	0	0	54.16	0	0	10	0.3	3.6
2025	4	7	18	12	55	0	0	0	0	0	0	0	54.14	0	0	10.4	0.3	3.6
2025	4	7	18	22	55	0	0	0	0	0	0	0	54.09	0	0	10.2	0.3	3.6
2025	4	7	18	32	55	0	0	0	0	0	0	0	54.03	0	0	10.2	0.3	3.6
2025	4	7	18	42	55	0	0	0	0	0	0	0	54	0	0	10.2	0.3	3.6
2025	4	7	18	52	55	0	0	0	0	0	0	0	53.92	0	0	10.2	0.3	3.6
2025	4	7	19	2	55	0	0	0	0	0	0	0	53.87	0	0	10.2	0.3	3.6
2025	4	7	19	12	55	0	0	0	0	0	0	0	53.8	0	0	10.2	0.3	3.6
2025	4	7	19	22	55	0	0	0	0	0	0	0	53.74	0	0	10	0.3	3.6
2025	4	7	19	32	55	0	0	0	0	0	0	0	53.67	0	0	10	0.3	3.6
2025	4	7	19	42	55	0	0	0	0	0	0	0	53.62	0	0	9.8	0.3	3.6
2025	4	7	19	52	55	0	0	0	0	0	0	0	53.53	0	0	11	0.3	3.6
2025	4	7	20	2	55	0	0	0	0	0	0	0	53.46	0	0	11.6	0.3	3.6
2025	4	7	20	12	55	0	0	0	0	0	0	0	53.38	0	0	11.6	0.3	3.6
2025	4	7	20	22	55	0	0	0	0	0	0	0	53.29	0	0	11.6	0.3	3.6
2025	4	7	20	32	55	0	0	0	0	0	0	0	53.22	0	0	11.6	0.3	3.6
2025	4	7	20	42	55	0	0	0	0	0	0	0	53.13	0	0	11.6	0.3	3.6
2025	4	7	20	52	55	0	0	0	0	0	0	0	53.06	0	0	11.6	0.3	3.6
2025	4	7	21	2	55	0	0	0	0	0	0	0	52.99	0	0	11.6	0.3	3.6
2025	4	7	21	12	55	0	0	0	0	0	0	0	52.9	0	0	11.6	0.3	3.6
2025	4	7	21	22	55	0	0	0	0	0	0	0	52.81	0	0	11.6	0.3	3.6
2025	4	7	21	32	55	0	0	0	0	0	0	0	52.74	0	0	11.6	0.3	3.6
2025	4	7	21	42	55	0	0	0	0	0	0	0	52.65	0	0	11.6	0.3	3.6
2025	4	7	21	52	55	0	0	0	0	0	0	0	52.54	0	0	11.6	0.3	3.6
2025	4	7	22	2	55	0	0	0	0	0	0	0	52.45	0	0	11.6	0.3	3.6
2025	4	7	22	12	55	0	0	0	0	0	0	0	52.36	0	0	11.6	0.3	3.6
2025	4	7	22	22	55	0	0	0	0	0	0	0	52.27	0	0	11.6	0.3	3.6
2025	4	7	22	32	55	0	0	0	0	0	0	0	52.18	0	0	11.6	0.3	3.6
2025	4	7	22	42	55	0	0	0	0	0	0	0	52.07	0	0	11.6	0.3	3.6
2025	4	7	22	52	55	0	0	0	0	0	0	0	51.98	0	0	11.6	0.3	3.6
2025	4	7	23	2	55	0	0	0	0	0	0	0	51.87	0	0	11.6	0.3	3.6
2025	4	7	23	12	55	0	0	0	0	0	0	0	51.8	0	0	11.6	0.3	3.6
2025	4	7	23	22	55	0	0	0	0	0	0	0	51.71	0	0	11.6	0.3	3.6
2025	4	7	23	32	55	0	0	0	0	0	0	0	51.62	0	0	11.6	0.3	3.6
2025	4	7	23	42	55	0	0	0	0	0	0	0	51.53	0	0	11.6	0.3	3.6
2025	4	7	23	52	55	0	0	0	0	0	0	0	51.44	0	0	11.6	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	8	0	2	55	0	0	0	0	0	0	0	51.37	0	0	11.6	0.3	3.6
2025	4	8	0	12	55	0	0	0	0	0	0	0	51.3	0	0	11.6	0.3	3.6
2025	4	8	0	22	55	0	0	0	0	0	0	0	51.22	0	0	11.6	0.3	3.6
2025	4	8	0	32	55	0	0	0	0	0	0	0	51.17	0	0	11.6	0.3	3.6
2025	4	8	0	42	55	0	0	0	0	0	0	0	51.1	0	0	11.6	0.3	3.6
2025	4	8	0	52	55	0	0	0	0	0	0	0	51.04	0	0	11.6	0.3	3.6
2025	4	8	1	2	55	0	0	0	0	0	0	0	50.99	0	0	11.6	0.3	3.6
2025	4	8	1	12	55	0	0	0	0	0	0	0	50.92	0	0	11.6	0.3	3.6
2025	4	8	1	22	55	0	0	0	0	0	0	0	50.88	0	0	11.6	0.3	3.6
2025	4	8	1	32	55	0	0	0	0	0	0	0	50.85	0	0	11.6	0.3	3.6
2025	4	8	1	42	55	0	0	0	0	0	0	0	50.79	0	0	11.4	0.3	3.6
2025	4	8	1	52	55	0	0	0	0	0	0	0	50.76	0	0	11.4	0.3	3.6
2025	4	8	2	2	55	0	0	0	0	0	0	0	50.72	0	0	11.4	0.3	3.6
2025	4	8	2	12	55	0	0	0	0	0	0	0	50.68	0	0	11.4	0.3	3.6
2025	4	8	2	22	55	0	0	0	0	0	0	0	50.65	0	0	11.4	0.3	3.6
2025	4	8	2	32	55	0	0	0	0	0	0	0	50.63	0	0	11.4	0.3	3.6
2025	4	8	2	42	55	0	0	0	0	0	0	0	50.61	0	0	11.4	0.3	3.6
2025	4	8	2	52	55	0	0	0	0	0	0	0	50.58	0	0	11.4	0.3	3.6
2025	4	8	3	2	55	0	0	0	0	0	0	0	50.56	0	0	11.4	0.3	3.6
2025	4	8	3	12	55	0	0	0	0	0	0	0	50.54	0	0	11.4	0.3	3.6
2025	4	8	3	22	55	0	0	0	0	0	0	0	50.54	0	0	11.4	0.3	3.6
2025	4	8	3	32	55	0	0	0	0	0	0	0	50.52	0	0	11.4	0.3	3.6
2025	4	8	3	42	55	0	0	0	0	0	0	0	50.52	0	0	11.4	0.3	3.6
2025	4	8	3	52	55	0	0	0	0	0	0	0	50.52	0	0	11.4	0.3	3.6
2025	4	8	4	2	55	0	0	0	0	0	0	0	50.52	0	0	11.4	0.3	3.6
2025	4	8	4	12	55	0	0	0	0	0	0	0	50.52	0	0	11.4	0.3	3.6
2025	4	8	4	22	55	0	0	0	0	0	0	0	50.52	0	0	11.4	0.3	3.6
2025	4	8	4	32	55	0	0	0	0	0	0	0	50.54	0	0	11.4	0.3	3.6
2025	4	8	4	42	55	0	0	0	0	0	0	0	50.54	0	0	11.4	0.3	3.6
2025	4	8	4	52	55	0	0	0	0	0	0	0	50.54	0	0	11.4	0.3	3.6
2025	4	8	5	2	55	0	0	0	0	0	0	0	50.56	0	0	11.4	0.3	3.6
2025	4	8	5	12	55	0	0	0	0	0	0	0	50.58	0	0	11.4	0.3	3.6
2025	4	8	5	22	55	0	0	0	0	0	0	0	50.58	0	0	11.4	0.3	3.6
2025	4	8	5	32	55	0	0	0	0	0	0	0	50.59	0	0	11.4	0.3	3.6
2025	4	8	5	42	55	0	0	0	0	0	0	0	50.61	0	0	11.4	0.3	3.6
2025	4	8	5	52	55	0	0	0	0	0	0	0	50.63	0	0	11.4	0.3	3.6
2025	4	8	6	2	55	0	0	0	0	0	0	0	50.65	0	0	11.4	0.3	3.6
2025	4	8	6	12	55	0	0	0	0	0	0	0	50.68	0	0	11.4	0.3	3.6
2025	4	8	6	22	55	0	0	0	0	0	0	0	50.7	0	0	11.4	0.3	3.6
2025	4	8	6	32	55	0	0	0	0	0	0	0	50.74	0	0	11.4	0.3	3.6
2025	4	8	6	42	55	0	0	0	0	0	0	0	50.77	0	0	11.4	0.3	3.6
2025	4	8	6	52	55	0	0	0	0	0	0	0	50.81	0	0	11.6	0.3	3.6
2025	4	8	7	2	55	0	0	0	0	0	0	0	50.85	0	0	11.6	0.3	3.6
2025	4	8	7	12	55	0	0	0	0	0	0	0	50.9	0	0	11.6	0.3	3.6
2025	4	8	7	22	55	0	0	0	0	0	0	0	50.94	0	0	11.4	0.3	3.6
2025	4	8	7	32	55	0	0	0	0	0	0	0	50.95	0	0	11.4	0.3	3.6
2025	4	8	7	42	55	0	0	0	0	0	0	0	50.99	0	0	11.6	0.3	3.6
2025	4	8	7	52	55	0	0	0	0	0	0	0	51.04	0	0	11.6	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	8	8	2	55	0	0	0	0	0	0	0	51.19	0	0	12.2	0.3	3.6
2025	4	8	8	12	55	0	0	0	0	0	0	0	51.28	0	0	12.6	0.3	3.6
2025	4	8	8	22	55	0	0	0	0	0	0	0	51.42	0	0	13	0.3	3.6
2025	4	8	8	32	55	0	0	0	0	0	0	0	51.55	0	0	13.4	0.3	3.6
2025	4	8	8	42	55	0	0	0	0	0	0	0	51.67	0	0	13.6	0.3	3.6
2025	4	8	8	52	55	0	0	0	0	0	0	0	51.82	0	0	13.8	0.3	3.6
2025	4	8	9	2	55	0	0	0	0	0	0	0	51.93	0	0	13.6	0.3	3.6
2025	4	8	9	12	55	0	0	0	0	0	0	0	52.05	0	0	13.6	0.3	3.6
2025	4	8	9	22	55	0	0	0	0	0	0	0	52.2	0	0	13.6	0.3	3.6
2025	4	8	9	32	55	0	0	0	0	0	0	0	52.32	0	0	13.4	0.3	3.6
2025	4	8	9	42	55	0	0	0	0	0	0	0	52.45	0	0	13.4	0.3	3.6
2025	4	8	9	52	55	0	0	0	0	0	0	0	52.57	0	0	13.4	0.3	3.6
2025	4	8	10	2	55	0	0	0	0	0	0	0	52.7	0	0	13.2	0.3	3.6
2025	4	8	10	12	55	0	0	0	0	0	0	0	52.79	0	0	13.2	0.3	3.6
2025	4	8	10	22	55	0	0	0	0	0	0	0	52.93	0	0	13.2	0.3	3.6
2025	4	8	10	32	55	0	0	0	0	0	0	0	53.04	0	0	13.2	0.3	3.6
2025	4	8	10	42	55	0	0	0	0	0	0	0	53.19	0	0	13.2	0.3	3.6
2025	4	8	10	52	55	0	0	0	0	0	0	0	53.29	0	0	13.2	0.3	3.6
2025	4	8	11	2	55	0	0	0	0	0	0	0	53.42	0	0	13.2	0.3	3.6
2025	4	8	11	12	55	0	0	0	0	0	0	0	53.55	0	0	13.2	0.3	3.6
2025	4	8	11	22	55	0	0	0	0	0	0	0	53.67	0	0	13.2	0.3	3.6
2025	4	8	11	32	55	0	0	0	0	0	0	0	53.8	0	0	13.2	0.3	3.6
2025	4	8	11	42	55	0	0	0	0	0	0	0	53.94	0	0	13.2	0.3	3.6
2025	4	8	11	52	55	0	0	0	0	0	0	0	54.07	0	0	13.2	0.3	3.6
2025	4	8	12	2	55	0	0	0	0	0	0	0	54.18	0	0	13.2	0.3	3.6
2025	4	8	12	12	55	0	0	0	0	0	0	0	54.3	0	0	13.2	0.3	3.6
2025	4	8	12	22	55	0	0	0	0	0	0	0	54.43	0	0	13.2	0.3	3.6
2025	4	8	12	32	55	0	0	0	0	0	0	0	54.55	0	0	13.2	0.3	3.6
2025	4	8	12	42	55	0	0	0	0	0	0	0	54.64	0	0	13.2	0.3	3.6
2025	4	8	12	52	55	0	0	0	0	0	0	0	54.75	0	0	13.2	0.3	3.6
2025	4	8	13	2	55	0	0	0	0	0	0	0	54.86	0	0	13.2	0.3	3.6
2025	4	8	13	12	55	0	0	0	0	0	0	0	54.97	0	0	13.2	0.3	3.6
2025	4	8	13	22	55	0	0	0	0	0	0	0	55.08	0	0	13.2	0.3	3.6
2025	4	8	13	32	55	0	0	0	0	0	0	0	55.18	0	0	11.8	0.3	3.6
2025	4	8	13	42	55	0	0	0	0	0	0	0	55.26	0	0	11.6	0.3	3.6
2025	4	8	13	52	55	0	0	0	0	0	0	0	55.36	0	0	11.6	0.3	3.6
2025	4	8	14	2	55	0	0	0	0	0	0	0	55.44	0	0	11.8	0.3	3.6
2025	4	8	14	12	55	0	0	0	0	0	0	0	55.51	0	0	12	0.3	3.6
2025	4	8	14	22	55	0	0	0	0	0	0	0	55.6	0	0	12.2	0.3	3.6
2025	4	8	14	32	55	0	0	0	0	0	0	0	55.67	0	0	12.6	0.3	3.6
2025	4	8	14	42	55	0	0	0	0	0	0	0	55.74	0	0	12.4	0.3	3.6
2025	4	8	14	52	55	0	0	0	0	0	0	0	55.81	0	0	12.4	0.3	3.6
2025	4	8	15	2	55	0	0	0	0	0	0	0	55.89	0	0	12.2	0.3	3.6
2025	4	8	15	12	55	0	0	0	0	0	0	0	55.94	0	0	12.2	0.3	3.6
2025	4	8	15	22	55	0	0	0	0	0	0	0	55.98	0	0	12	0.3	3.6
2025	4	8	15	32	55	0	0	0	0	0	0	0	56.03	0	0	11.8	0.3	3.6
2025	4	8	15	42	55	0	0	0	0	0	0	0	56.08	0	0	11.6	0.3	3.6
2025	4	8	15	52	55	0	0	0	0	0	0	0	56.12	0	0	11.6	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	8	16	2	55	0	0	0	0	0	0	0	56.12	0	0	11.2	0.3	3.6
2025	4	8	16	12	55	0	0	0	0	0	0	0	56.16	0	0	11.2	0.3	3.6
2025	4	8	16	22	55	0	0	0	0	0	0	0	56.19	0	0	11.6	0.3	3.6
2025	4	8	16	32	55	0	0	0	0	0	0	0	56.19	0	0	11.4	0.3	3.6
2025	4	8	16	42	55	0	0	0	0	0	0	0	56.21	0	0	11	0.3	3.6
2025	4	8	16	52	55	0	0	0	0	0	0	0	56.19	0	0	10.8	0.3	3.6
2025	4	8	17	2	55	0	0	0	0	0	0	0	56.19	0	0	10.6	0.3	3.6
2025	4	8	17	12	55	0	0	0	0	0	0	0	56.21	0	0	10.8	0.3	3.6
2025	4	8	17	22	55	0	0	0	0	0	0	0	56.19	0	0	11.2	0.3	3.6
2025	4	8	17	32	55	0	0	0	0	0	0	0	56.21	0	0	10.8	0.3	3.6
2025	4	8	17	42	55	0	0	0	0	0	0	0	56.19	0	0	10	0.3	3.6
2025	4	8	17	52	55	0	0	0	0	0	0	0	56.19	0	0	9.6	0.3	3.6
2025	4	8	18	2	55	0	0	0	0	0	0	0	56.19	0	0	9.6	0.3	3.6
2025	4	8	18	12	55	0	0	0	0	0	0	0	56.16	0	0	9.6	0.3	3.6
2025	4	8	18	22	55	0	0	0	0	0	0	0	56.14	0	0	9.4	0.3	3.6
2025	4	8	18	32	55	0	0	0	0	0	0	0	56.1	0	0	10.2	0.3	3.6
2025	4	8	18	42	55	0	0	0	0	0	0	0	56.07	0	0	10.6	0.3	3.6
2025	4	8	18	52	55	0	0	0	0	0	0	0	56.03	0	0	10.4	0.3	3.6
2025	4	8	19	2	55	0	0	0	0	0	0	0	55.96	0	0	10.2	0.3	3.6
2025	4	8	19	12	55	0	0	0	0	0	0	0	55.92	0	0	10	0.3	3.6
2025	4	8	19	22	55	0	0	0	0	0	0	0	55.87	0	0	10	0.3	3.6
2025	4	8	19	32	55	0	0	0	0	0	0	0	55.78	0	0	10.8	0.3	3.6
2025	4	8	19	42	55	0	0	0	0	0	0	0	55.71	0	0	10.8	0.3	3.6
2025	4	8	19	52	55	0	0	0	0	0	0	0	55.63	0	0	11	0.3	3.6
2025	4	8	20	2	55	0	0	0	0	0	0	0	55.54	0	0	10.8	0.3	3.6
2025	4	8	20	12	55	0	0	0	0	0	0	0	55.45	0	0	10.8	0.3	3.6
2025	4	8	20	22	55	0	0	0	0	0	0	0	55.36	0	0	11	0.3	3.6
2025	4	8	20	32	55	0	0	0	0	0	0	0	55.27	0	0	10.8	0.3	3.6
2025	4	8	20	42	55	0	0	0	0	0	0	0	55.17	0	0	11.2	0.3	3.6
2025	4	8	20	52	55	0	0	0	0	0	0	0	55.08	0	0	11	0.3	3.6
2025	4	8	21	2	55	0	0	0	0	0	0	0	54.99	0	0	10.8	0.3	3.6
2025	4	8	21	12	55	0	0	0	0	0	0	0	54.88	0	0	11	0.3	3.6
2025	4	8	21	22	55	0	0	0	0	0	0	0	54.79	0	0	11	0.3	3.6
2025	4	8	21	32	55	0	0	0	0	0	0	0	54.68	0	0	11	0.3	3.6
2025	4	8	21	42	55	0	0	0	0	0	0	0	54.57	0	0	10.8	0.3	3.6
2025	4	8	21	52	55	0	0	0	0	0	0	0	54.46	0	0	10.8	0.3	3.6
2025	4	8	22	2	55	0	0	0	0	0	0	0	54.36	0	0	10.8	0.3	3.6
2025	4	8	22	12	55	0	0	0	0	0	0	0	54.27	0	0	10.8	0.3	3.6
2025	4	8	22	22	55	0	0	0	0	0	0	0	54.16	0	0	10.8	0.3	3.6
2025	4	8	22	32	55	0	0	0	0	0	0	0	54.05	0	0	10.8	0.3	3.6
2025	4	8	22	42	55	0	0	0	0	0	0	0	53.96	0	0	10.6	0.3	3.6
2025	4	8	22	52	55	0	0	0	0	0	0	0	53.87	0	0	10.4	0.3	3.6
2025	4	8	23	2	55	0	0	0	0	0	0	0	53.74	0	0	10.4	0.3	3.6
2025	4	8	23	12	55	0	0	0	0	0	0	0	53.65	0	0	10.2	0.3	3.6
2025	4	8	23	22	55	0	0	0	0	0	0	0	53.56	0	0	10	0.3	3.6
2025	4	8	23	32	55	0	0	0	0	0	0	0	53.47	0	0	10.2	0.3	3.6
2025	4	8	23	42	55	0	0	0	0	0	0	0	53.38	0	0	10.2	0.3	3.6
2025	4	8	23	52	55	0	0	0	0	0	0	0	53.29	0	0	10	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	9	0	2	55	0	0	0	0	0	0	0	53.22	0	0	10	0.3	3.6
2025	4	9	0	12	55	0	0	0	0	0	0	0	53.11	0	0	10	0.3	3.6
2025	4	9	0	22	55	0	0	0	0	0	0	0	53.06	0	0	9.8	0.3	3.6
2025	4	9	0	32	55	0	0	0	0	0	0	0	52.99	0	0	10.2	0.3	3.6
2025	4	9	0	42	55	0	0	0	0	0	0	0	52.92	0	0	11	0.3	3.6
2025	4	9	0	52	55	0	0	0	0	0	0	0	52.86	0	0	10.8	0.3	3.6
2025	4	9	1	2	55	0	0	0	0	0	0	0	52.81	0	0	11	0.3	3.6
2025	4	9	1	12	55	0	0	0	0	0	0	0	52.75	0	0	11	0.3	3.6
2025	4	9	1	22	55	0	0	0	0	0	0	0	52.7	0	0	11	0.3	3.6
2025	4	9	1	32	55	0	0	0	0	0	0	0	52.65	0	0	11	0.3	3.6
2025	4	9	1	42	55	0	0	0	0	0	0	0	52.61	0	0	11.4	0.3	3.6
2025	4	9	1	52	55	0	0	0	0	0	0	0	52.57	0	0	11.4	0.3	3.6
2025	4	9	2	2	55	0	0	0	0	0	0	0	52.54	0	0	11.4	0.3	3.6
2025	4	9	2	12	55	0	0	0	0	0	0	0	52.5	0	0	11.4	0.3	3.6
2025	4	9	2	22	55	0	0	0	0	0	0	0	52.48	0	0	11.4	0.3	3.6
2025	4	9	2	32	55	0	0	0	0	0	0	0	52.45	0	0	11.4	0.3	3.6
2025	4	9	2	42	55	0	0	0	0	0	0	0	52.43	0	0	11.4	0.3	3.6
2025	4	9	2	52	55	0	0	0	0	0	0	0	52.41	0	0	11.4	0.3	3.6
2025	4	9	3	2	55	0	0	0	0	0	0	0	52.41	0	0	11.4	0.3	3.6
2025	4	9	3	12	55	0	0	0	0	0	0	0	52.39	0	0	11.4	0.3	3.6
2025	4	9	3	22	55	0	0	0	0	0	0	0	52.38	0	0	11.4	0.3	3.6
2025	4	9	3	32	55	0	0	0	0	0	0	0	52.38	0	0	11.4	0.3	3.6
2025	4	9	3	42	55	0	0	0	0	0	0	0	52.38	0	0	11.4	0.3	3.6
2025	4	9	3	52	55	0	0	0	0	0	0	0	52.36	0	0	11.4	0.3	3.6
2025	4	9	4	2	55	0	0	0	0	0	0	0	52.36	0	0	11.4	0.3	3.6
2025	4	9	4	12	55	0	0	0	0	0	0	0	52.38	0	0	11.4	0.3	3.6
2025	4	9	4	22	55	0	0	0	0	0	0	0	52.38	0	0	11.4	0.3	3.6
2025	4	9	4	32	55	0	0	0	0	0	0	0	52.38	0	0	11.4	0.3	3.6
2025	4	9	4	42	55	0	0	0	0	0	0	0	52.39	0	0	11.4	0.3	3.6
2025	4	9	4	52	55	0	0	0	0	0	0	0	52.39	0	0	11.4	0.3	3.6
2025	4	9	5	2	55	0	0	0	0	0	0	0	52.41	0	0	11.4	0.3	3.6
2025	4	9	5	12	55	0	0	0	0	0	0	0	52.43	0	0	11.4	0.3	3.6
2025	4	9	5	22	55	0	0	0	0	0	0	0	52.45	0	0	11.4	0.3	3.6
2025	4	9	5	32	55	0	0	0	0	0	0	0	52.47	0	0	11.4	0.3	3.6
2025	4	9	5	42	55	0	0	0	0	0	0	0	52.47	0	0	11.4	0.3	3.6
2025	4	9	5	52	55	0	0	0	0	0	0	0	52.48	0	0	11.4	0.3	3.6
2025	4	9	6	2	55	0	0	0	0	0	0	0	52.5	0	0	11.4	0.3	3.6
2025	4	9	6	12	55	0	0	0	0	0	0	0	52.52	0	0	11.4	0.3	3.6
2025	4	9	6	22	55	0	0	0	0	0	0	0	52.54	0	0	11.6	0.3	3.6
2025	4	9	6	32	55	0	0	0	0	0	0	0	52.57	0	0	11.6	0.3	3.6
2025	4	9	6	42	55	0	0	0	0	0	0	0	52.59	0	0	11.8	0.3	3.6
2025	4	9	6	52	55	0	0	0	0	0	0	0	52.65	0	0	12	0.3	3.6
2025	4	9	7	2	55	0	0	0	0	0	0	0	52.7	0	0	12.2	0.3	3.6
2025	4	9	7	12	55	0	0	0	0	0	0	0	52.74	0	0	12.4	0.3	3.6
2025	4	9	7	22	55	0	0	0	0	0	0	0	52.83	0	0	12.4	0.3	3.6
2025	4	9	7	32	55	0	0	0	0	0	0	0	52.93	0	0	12.6	0.3	3.6
2025	4	9	7	42	55	0	0	0	0	0	0	0	53.02	0	0	12.6	0.3	3.6
2025	4	9	7	52	55	0	0	0	0	0	0	0	53.11	0	0	12.8	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	9	8	2	55	0	0	0	0	0	0	0	53.22	0	0	12.8	0.3	3.6
2025	4	9	8	12	55	0	0	0	0	0	0	0	53.33	0	0	13.4	0.3	3.6
2025	4	9	8	22	55	0	0	0	0	0	0	0	53.44	0	0	13.4	0.3	3.6
2025	4	9	8	32	55	0	0	0	0	0	0	0	53.53	0	0	13.6	0.3	3.6
2025	4	9	8	42	55	0	0	0	0	0	0	0	53.65	0	0	13.6	0.3	3.6
2025	4	9	8	52	55	0	0	0	0	0	0	0	53.76	0	0	13.4	0.3	3.6
2025	4	9	9	2	55	0	0	0	0	0	0	0	53.89	0	0	13.4	0.3	3.6
2025	4	9	9	12	55	0	0	0	0	0	0	0	54.01	0	0	13.2	0.3	3.6
2025	4	9	9	22	55	0	0	0	0	0	0	0	54.12	0	0	13	0.3	3.6
2025	4	9	9	32	55	0	0	0	0	0	0	0	54.27	0	0	12.8	0.3	3.6
2025	4	9	9	42	55	0	0	0	0	0	0	0	54.36	0	0	12.6	0.3	3.6
2025	4	9	9	52	55	0	0	0	0	0	0	0	54.5	0	0	12.6	0.3	3.6
2025	4	9	10	2	55	0	0	0	0	0	0	0	54.63	0	0	12.6	0.3	3.6
2025	4	9	10	12	55	0	0	0	0	0	0	0	54.73	0	0	12.8	0.3	3.6
2025	4	9	10	22	55	0	0	0	0	0	0	0	54.9	0	0	12.8	0.3	3.6
2025	4	9	10	32	55	0	0	0	0	0	0	0	55.02	0	0	12.8	0.3	3.6
2025	4	9	10	42	55	0	0	0	0	0	0	0	55.15	0	0	12.6	0.3	3.6
2025	4	9	10	52	55	0	0	0	0	0	0	0	55.29	0	0	12.8	0.3	3.6
2025	4	9	11	2	55	0	0	0	0	0	0	0	55.4	0	0	12.8	0.3	3.6
2025	4	9	11	12	55	0	0	0	0	0	0	0	55.53	0	0	12.6	0.3	3.6
2025	4	9	11	22	55	0	0	0	0	0	0	0	55.67	0	0	12.4	0.3	3.6
2025	4	9	11	32	55	0	0	0	0	0	0	0	55.81	0	0	12.6	0.3	3.6
2025	4	9	11	42	55	0	0	0	0	0	0	0	55.9	0	0	12.4	0.3	3.6
2025	4	9	11	52	55	0	0	0	0	0	0	0	56.03	0	0	12.2	0.3	3.6
2025	4	9	12	2	55	0	0	0	0	0	0	0	56.16	0	0	12.6	0.3	3.6
2025	4	9	12	12	55	0	0	0	0	0	0	0	56.26	0	0	12.8	0.3	3.6
2025	4	9	12	22	55	0	0	0	0	0	0	0	56.41	0	0	12.8	0.3	3.6
2025	4	9	12	32	55	0	0	0	0	0	0	0	56.52	0	0	12.4	0.3	3.6
2025	4	9	12	42	55	0	0	0	0	0	0	0	56.64	0	0	12.4	0.3	3.6
2025	4	9	12	52	55	0	0	0	0	0	0	0	56.73	0	0	12.6	0.3	3.6
2025	4	9	13	2	55	0	0	0	0	0	0	0	56.84	0	0	12.4	0.3	3.6
2025	4	9	13	12	55	0	0	0	0	0	0	0	56.97	0	0	12.4	0.3	3.6
2025	4	9	13	22	55	0	0	0	0	0	0	0	57.07	0	0	12.6	0.3	3.6
2025	4	9	13	32	55	0	0	0	0	0	0	0	57.16	0	0	12.6	0.3	3.6
2025	4	9	13	42	55	0	0	0	0	0	0	0	57.25	0	0	12.6	0.3	3.6
2025	4	9	13	52	55	0	0	0	0	0	0	0	57.36	0	0	12.6	0.3	3.6
2025	4	9	14	2	55	0	0	0	0	0	0	0	57.43	0	0	12.4	0.3	3.6
2025	4	9	14	12	55	0	0	0	0	0	0	0	57.51	0	0	12.4	0.3	3.6
2025	4	9	14	22	55	0	0	0	0	0	0	0	57.6	0	0	12.8	0.3	3.6
2025	4	9	14	32	55	0	0	0	0	0	0	0	57.69	0	0	12.6	0.3	3.6
2025	4	9	14	42	55	0	0	0	0	0	0	0	57.74	0	0	12.4	0.3	3.6
2025	4	9	14	52	55	0	0	0	0	0	0	0	57.79	0	0	12.4	0.3	3.6
2025	4	9	15	2	55	0	0	0	0	0	0	0	57.87	0	0	12.6	0.3	3.6
2025	4	9	15	12	55	0	0	0	0	0	0	0	57.92	0	0	12.4	0.3	3.6
2025	4	9	15	22	55	0	0	0	0	0	0	0	57.97	0	0	12.4	0.3	3.6
2025	4	9	15	32	55	0	0	0	0	0	0	0	58.03	0	0	12.2	0.3	3.6
2025	4	9	15	42	55	0	0	0	0	0	0	0	58.08	0	0	12.2	0.3	3.6
2025	4	9	15	52	55	0	0	0	0	0	0	0	58.1	0	0	12	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	9	16	2	55	0	0	0	0	0	0	0	58.14	0	0	11.8	0.3	3.6
2025	4	9	16	12	55	0	0	0	0	0	0	0	58.15	0	0	10.6	0.3	3.6
2025	4	9	16	22	55	0	0	0	0	0	0	0	58.19	0	0	11.4	0.3	3.6
2025	4	9	16	32	55	0	0	0	0	0	0	0	58.19	0	0	12	0.3	3.6
2025	4	9	16	42	55	0	0	0	0	0	0	0	58.21	0	0	12	0.3	3.6
2025	4	9	16	52	55	0	0	0	0	0	0	0	58.19	0	0	11.8	0.3	3.6
2025	4	9	17	2	55	0	0	0	0	0	0	0	58.19	0	0	11.8	0.3	3.6
2025	4	9	17	12	55	0	0	0	0	0	0	0	58.19	0	0	11.8	0.3	3.6
2025	4	9	17	22	55	0	0	0	0	0	0	0	58.17	0	0	11.8	0.3	3.6
2025	4	9	17	32	55	0	0	0	0	0	0	0	58.17	0	0	11.6	0.3	3.6
2025	4	9	17	42	55	0	0	0	0	0	0	0	58.15	0	0	11.6	0.3	3.6
2025	4	9	17	52	55	0	0	0	0	0	0	0	58.14	0	0	11.6	0.3	3.6
2025	4	9	18	2	55	0	0	0	0	0	0	0	58.12	0	0	11.6	0.3	3.6
2025	4	9	18	12	55	0	0	0	0	0	0	0	58.1	0	0	11.6	0.3	3.6
2025	4	9	18	22	55	0	0	0	0	0	0	0	58.06	0	0	11.6	0.3	3.6
2025	4	9	18	32	55	0	0	0	0	0	0	0	58.03	0	0	11.6	0.3	3.6
2025	4	9	18	42	55	0	0	0	0	0	0	0	57.99	0	0	11.6	0.3	3.6
2025	4	9	18	52	55	0	0	0	0	0	0	0	57.94	0	0	11.6	0.3	3.6
2025	4	9	19	2	55	0	0	0	0	0	0	0	57.9	0	0	11.6	0.3	3.6
2025	4	9	19	12	55	0	0	0	0	0	0	0	57.85	0	0	11.6	0.3	3.6
2025	4	9	19	22	55	0	0	0	0	0	0	0	57.79	0	0	11.6	0.3	3.6
2025	4	9	19	32	55	0	0	0	0	0	0	0	57.74	0	0	11.6	0.3	3.6
2025	4	9	19	42	55	0	0	0	0	0	0	0	57.65	0	0	11.6	0.3	3.6
2025	4	9	19	52	55	0	0	0	0	0	0	0	57.58	0	0	11.6	0.3	3.6
2025	4	9	20	2	55	0	0	0	0	0	0	0	57.49	0	0	11.6	0.3	3.6
2025	4	9	20	12	55	0	0	0	0	0	0	0	57.42	0	0	11.6	0.3	3.6
2025	4	9	20	22	55	0	0	0	0	0	0	0	57.33	0	0	11.6	0.3	3.6
2025	4	9	20	32	55	0	0	0	0	0	0	0	57.22	0	0	11.6	0.3	3.6
2025	4	9	20	42	55	0	0	0	0	0	0	0	57.15	0	0	11.6	0.3	3.6
2025	4	9	20	52	55	0	0	0	0	0	0	0	57.02	0	0	11.6	0.3	3.6
2025	4	9	21	2	55	0	0	0	0	0	0	0	56.93	0	0	11	0.3	3.6
2025	4	9	21	12	55	0	0	0	0	0	0	0	56.82	0	0	10.8	0.3	3.6
2025	4	9	21	22	55	0	0	0	0	0	0	0	56.73	0	0	10.8	0.3	3.6
2025	4	9	21	32	55	0	0	0	0	0	0	0	56.64	0	0	10.8	0.3	3.6
2025	4	9	21	42	55	0	0	0	0	0	0	0	56.53	0	0	10.8	0.3	3.6
2025	4	9	21	52	55	0	0	0	0	0	0	0	56.43	0	0	10.8	0.3	3.6
2025	4	9	22	2	55	0	0	0	0	0	0	0	56.34	0	0	11	0.3	3.6
2025	4	9	22	12	55	0	0	0	0	0	0	0	56.25	0	0	11	0.3	3.6
2025	4	9	22	22	55	0	0	0	0	0	0	0	56.16	0	0	11	0.3	3.6
2025	4	9	22	32	55	0	0	0	0	0	0	0	56.05	0	0	10.8	0.3	3.6
2025	4	9	22	42	55	0	0	0	0	0	0	0	55.96	0	0	10.8	0.3	3.6
2025	4	9	22	52	55	0	0	0	0	0	0	0	55.87	0	0	10.8	0.3	3.6
2025	4	9	23	2	55	0	0	0	0	0	0	0	55.78	0	0	10.6	0.3	3.6
2025	4	9	23	12	55	0	0	0	0	0	0	0	55.69	0	0	10.8	0.3	3.6
2025	4	9	23	22	55	0	0	0	0	0	0	0	55.6	0	0	10.8	0.3	3.6
2025	4	9	23	32	55	0	0	0	0	0	0	0	55.53	0	0	11	0.3	3.6
2025	4	9	23	42	55	0	0	0	0	0	0	0	55.44	0	0	11	0.3	3.6
2025	4	9	23	52	55	0	0	0	0	0	0	0	55.36	0	0	11	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	10	0	2	55	0	0	0	0	0	0	0	55.27	0	0	11.2	0.3	3.6
2025	4	10	0	12	55	0	0	0	0	0	0	0	55.2	0	0	11.4	0.3	3.6
2025	4	10	0	22	55	0	0	0	0	0	0	0	55.13	0	0	11.4	0.3	3.6
2025	4	10	0	32	55	0	0	0	0	0	0	0	55.08	0	0	11.4	0.3	3.6
2025	4	10	0	42	55	0	0	0	0	0	0	0	54.99	0	0	11.2	0.3	3.6
2025	4	10	0	52	55	0	0	0	0	0	0	0	54.93	0	0	11.2	0.3	3.6
2025	4	10	1	2	55	0	0	0	0	0	0	0	54.88	0	0	11.4	0.3	3.6
2025	4	10	1	12	55	0	0	0	0	0	0	0	54.82	0	0	11.4	0.3	3.6
2025	4	10	1	22	55	0	0	0	0	0	0	0	54.77	0	0	11	0.3	3.6
2025	4	10	1	32	55	0	0	0	0	0	0	0	54.72	0	0	10.8	0.3	3.6
2025	4	10	1	42	55	0	0	0	0	0	0	0	54.68	0	0	11	0.3	3.6
2025	4	10	1	52	55	0	0	0	0	0	0	0	54.64	0	0	11.4	0.3	3.6
2025	4	10	2	2	55	0	0	0	0	0	0	0	54.59	0	0	11.4	0.3	3.6
2025	4	10	2	12	55	0	0	0	0	0	0	0	54.57	0	0	11.4	0.3	3.6
2025	4	10	2	22	55	0	0	0	0	0	0	0	54.54	0	0	11.4	0.3	3.6
2025	4	10	2	32	55	0	0	0	0	0	0	0	54.52	0	0	11.4	0.3	3.6
2025	4	10	2	42	55	0	0	0	0	0	0	0	54.48	0	0	11.4	0.3	3.6
2025	4	10	2	52	55	0	0	0	0	0	0	0	54.48	0	0	11.4	0.3	3.6
2025	4	10	3	2	55	0	0	0	0	0	0	0	54.46	0	0	11.4	0.3	3.6
2025	4	10	3	12	55	0	0	0	0	0	0	0	54.45	0	0	11.4	0.3	3.6
2025	4	10	3	22	55	0	0	0	0	0	0	0	54.43	0	0	11.4	0.3	3.6
2025	4	10	3	32	55	0	0	0	0	0	0	0	54.43	0	0	11.4	0.3	3.6
2025	4	10	3	42	55	0	0	0	0	0	0	0	54.43	0	0	11.4	0.3	3.6
2025	4	10	3	52	55	0	0	0	0	0	0	0	54.43	0	0	11.4	0.3	3.6
2025	4	10	4	2	55	0	0	0	0	0	0	0	54.43	0	0	11.4	0.3	3.6
2025	4	10	4	12	55	0	0	0	0	0	0	0	54.43	0	0	11.4	0.3	3.6
2025	4	10	4	22	55	0	0	0	0	0	0	0	54.43	0	0	11.4	0.3	3.6
2025	4	10	4	32	55	0	0	0	0	0	0	0	54.45	0	0	11.4	0.3	3.6
2025	4	10	4	42	55	0	0	0	0	0	0	0	54.45	0	0	11.4	0.3	3.6
2025	4	10	4	52	55	0	0	0	0	0	0	0	54.45	0	0	11.4	0.3	3.6
2025	4	10	5	2	55	0	0	0	0	0	0	0	54.46	0	0	11.4	0.3	3.6
2025	4	10	5	12	55	0	0	0	0	0	0	0	54.46	0	0	11.4	0.3	3.6
2025	4	10	5	22	55	0	0	0	0	0	0	0	54.46	0	0	11.4	0.3	3.6
2025	4	10	5	32	55	0	0	0	0	0	0	0	54.48	0	0	11.4	0.3	3.6
2025	4	10	5	42	55	0	0	0	0	0	0	0	54.5	0	0	11.4	0.3	3.6
2025	4	10	5	52	55	0	0	0	0	0	0	0	54.52	0	0	11.2	0.3	3.6
2025	4	10	6	2	55	0	0	0	0	0	0	0	54.52	0	0	10.8	0.3	3.6
2025	4	10	6	12	55	0	0	0	0	0	0	0	54.55	0	0	10.4	0.3	3.6
2025	4	10	6	22	55	0	0	0	0	0	0	0	54.55	0	0	11	0.3	3.6
2025	4	10	6	32	55	0	0	0	0	0	0	0	54.59	0	0	11.2	0.3	3.6
2025	4	10	6	42	55	0	0	0	0	0	0	0	54.63	0	0	11.4	0.3	3.6
2025	4	10	6	52	55	0	0	0	0	0	0	0	54.7	0	0	11.6	0.3	3.6
2025	4	10	7	2	55	0	0	0	0	0	0	0	54.73	0	0	11.6	0.3	3.6
2025	4	10	7	12	55	0	0	0	0	0	0	0	54.79	0	0	11.8	0.3	3.6
2025	4	10	7	22	55	0	0	0	0	0	0	0	54.9	0	0	11.6	0.3	3.6
2025	4	10	7	32	55	0	0	0	0	0	0	0	55.02	0	0	12	0.3	3.6
2025	4	10	7	42	55	0	0	0	0	0	0	0	55.11	0	0	12	0.3	3.6
2025	4	10	7	52	55	0	0	0	0	0	0	0	55.2	0	0	12.2	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	10	8	2	55	0	0	0	0	0	0	0	55.33	0	0	12.6	0.3	3.6
2025	4	10	8	12	55	0	0	0	0	0	0	0	55.44	0	0	12.6	0.3	3.6
2025	4	10	8	22	55	0	0	0	0	0	0	0	55.53	0	0	12.8	0.3	3.6
2025	4	10	8	32	55	0	0	0	0	0	0	0	55.65	0	0	13	0.3	3.6
2025	4	10	8	42	55	0	0	0	0	0	0	0	55.76	0	0	13	0.3	3.6
2025	4	10	8	52	55	0	0	0	0	0	0	0	55.87	0	0	12.8	0.3	3.6
2025	4	10	9	2	55	0	0	0	0	0	0	0	56.03	0	0	12.8	0.3	3.6
2025	4	10	9	12	55	0	0	0	0	0	0	0	56.14	0	0	12.6	0.3	3.6
2025	4	10	9	22	55	0	0	0	0	0	0	0	56.25	0	0	13	0.3	3.6
2025	4	10	9	32	55	0	0	0	0	0	0	0	56.37	0	0	12.8	0.3	3.6
2025	4	10	9	42	55	0	0	0	0	0	0	0	56.5	0	0	12.8	0.3	3.6
2025	4	10	9	52	55	0	0	0	0	0	0	0	56.64	0	0	12.8	0.3	3.6
2025	4	10	10	2	55	0	0	0	0	0	0	0	56.75	0	0	12.6	0.3	3.6
2025	4	10	10	12	55	0	0	0	0	0	0	0	56.88	0	0	12.6	0.3	3.6
2025	4	10	10	22	55	0	0	0	0	0	0	0	57	0	0	12.4	0.3	3.6
2025	4	10	10	32	55	0	0	0	0	0	0	0	57.16	0	0	12.2	0.3	3.6
2025	4	10	10	42	55	0	0	0	0	0	0	0	57.27	0	0	12.4	0.3	3.6
2025	4	10	10	52	55	0	0	0	0	0	0	0	57.4	0	0	12.4	0.3	3.6
2025	4	10	11	2	55	0	0	0	0	0	0	0	57.52	0	0	12.4	0.3	3.6
2025	4	10	11	12	55	0	0	0	0	0	0	0	57.65	0	0	12.4	0.3	3.6
2025	4	10	11	22	55	0	0	0	0	0	0	0	57.79	0	0	12.6	0.3	3.6
2025	4	10	11	32	55	0	0	0	0	0	0	0	57.87	0	0	12.2	0.3	3.6
2025	4	10	11	42	55	0	0	0	0	0	0	0	57.96	0	0	12.6	0.3	3.6
2025	4	10	11	52	55	0	0	0	0	0	0	0	58.01	0	0	12.8	0.3	3.6
2025	4	10	12	2	55	0	0	0	0	0	0	0	58.19	0	0	12.8	0.3	3.6
2025	4	10	12	12	55	0	0	0	0	0	0	0	58.32	0	0	12.8	0.3	3.6
2025	4	10	12	22	55	0	0	0	0	0	0	0	58.42	0	0	12.6	0.3	3.6
2025	4	10	12	32	55	0	0	0	0	0	0	0	58.55	0	0	12.6	0.3	3.6
2025	4	10	12	42	55	0	0	0	0	0	0	0	58.66	0	0	12.4	0.3	3.6
2025	4	10	12	52	55	0	0	0	0	0	0	0	58.78	0	0	12.8	0.3	3.6
2025	4	10	13	2	55	0	0	0	0	0	0	0	58.87	0	0	12.6	0.3	3.6
2025	4	10	13	12	55	0	0	0	0	0	0	0	59	0	0	12.4	0.3	3.6
2025	4	10	13	22	55	0	0	0	0	0	0	0	59.09	0	0	12.4	0.3	3.6
2025	4	10	13	32	55	0	0	0	0	0	0	0	59.18	0	0	12.6	0.3	3.6
2025	4	10	13	42	55	0	0	0	0	0	0	0	59.29	0	0	12.6	0.3	3.6
2025	4	10	13	52	55	0	0	0	0	0	0	0	59.36	0	0	12.6	0.3	3.6
2025	4	10	14	2	55	0	0	0	0	0	0	0	59.45	0	0	12.4	0.3	3.6
2025	4	10	14	12	55	0	0	0	0	0	0	0	59.52	0	0	12.8	0.3	3.6
2025	4	10	14	22	55	0	0	0	0	0	0	0	59.59	0	0	12.6	0.3	3.6
2025	4	10	14	32	55	0	0	0	0	0	0	0	59.67	0	0	12.8	0.3	3.6
2025	4	10	14	42	55	0	0	0	0	0	0	0	59.74	0	0	12.8	0.3	3.6
2025	4	10	14	52	55	0	0	0	0	0	0	0	59.79	0	0	12.6	0.3	3.6
2025	4	10	15	2	55	0	0	0	0	0	0	0	59.85	0	0	12	0.3	3.6
2025	4	10	15	12	55	0	0	0	0	0	0	0	59.9	0	0	11.6	0.3	3.6
2025	4	10	15	22	55	0	0	0	0	0	0	0	59.95	0	0	11.4	0.3	3.6
2025	4	10	15	32	55	0	0	0	0	0	0	0	59.97	0	0	13	0.3	3.6
2025	4	10	15	42	55	0	0	0	0	0	0	0	60.01	0	0	13	0.3	3.6
2025	4	10	15	52	55	0	0	0	0	0	0	0	60.04	0	0	13	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	10	16	2	55	0	0	0	0	0	0	0	60.08	0	0	12.6	0.3	3.6
2025	4	10	16	12	55	0	0	0	0	0	0	0	60.1	0	0	12.2	0.3	3.6
2025	4	10	16	22	55	0	0	0	0	0	0	0	60.12	0	0	12.2	0.3	3.6
2025	4	10	16	32	55	0	0	0	0	0	0	0	60.13	0	0	12	0.3	3.6
2025	4	10	16	42	55	0	0	0	0	0	0	0	60.12	0	0	11.8	0.3	3.6
2025	4	10	16	52	55	0	0	0	0	0	0	0	60.1	0	0	11.8	0.3	3.6
2025	4	10	17	2	55	0	0	0	0	0	0	0	60.1	0	0	11.6	0.3	3.6
2025	4	10	17	12	55	0	0	0	0	0	0	0	60.08	0	0	11.6	0.3	3.6
2025	4	10	17	22	55	0	0	0	0	0	0	0	60.06	0	0	11.6	0.3	3.6
2025	4	10	17	32	55	0	0	0	0	0	0	0	60.04	0	0	11.6	0.3	3.6
2025	4	10	17	42	55	0	0	0	0	0	0	0	60.03	0	0	11.6	0.3	3.6
2025	4	10	17	52	55	0	0	0	0	0	0	0	59.99	0	0	11.4	0.3	3.6
2025	4	10	18	2	55	0	0	0	0	0	0	0	59.97	0	0	11.4	0.3	3.6
2025	4	10	18	12	55	0	0	0	0	0	0	0	59.94	0	0	11.4	0.3	3.6
2025	4	10	18	22	55	0	0	0	0	0	0	0	59.9	0	0	11.4	0.3	3.6
2025	4	10	18	32	55	0	0	0	0	0	0	0	59.85	0	0	11.4	0.3	3.6
2025	4	10	18	42	55	0	0	0	0	0	0	0	59.81	0	0	11.4	0.3	3.6
2025	4	10	18	52	55	0	0	0	0	0	0	0	59.74	0	0	11.4	0.3	3.6
2025	4	10	19	2	55	0	0	0	0	0	0	0	59.68	0	0	11.4	0.3	3.6
2025	4	10	19	12	55	0	0	0	0	0	0	0	59.63	0	0	11.4	0.3	3.6
2025	4	10	19	22	55	0	0	0	0	0	0	0	59.54	0	0	11.4	0.3	3.6
2025	4	10	19	32	55	0	0	0	0	0	0	0	59.49	0	0	11.4	0.3	3.6
2025	4	10	19	42	55	0	0	0	0	0	0	0	59.4	0	0	11.4	0.3	3.6
2025	4	10	19	52	55	0	0	0	0	0	0	0	59.32	0	0	11.4	0.3	3.6
2025	4	10	20	2	55	0	0	0	0	0	0	0	59.23	0	0	11.4	0.3	3.6
2025	4	10	20	12	55	0	0	0	0	0	0	0	59.14	0	0	11.4	0.3	3.6
2025	4	10	20	22	55	0	0	0	0	0	0	0	59.05	0	0	11.4	0.3	3.6
2025	4	10	20	32	55	0	0	0	0	0	0	0	58.96	0	0	11.4	0.3	3.6
2025	4	10	20	42	55	0	0	0	0	0	0	0	58.86	0	0	11.4	0.3	3.6
2025	4	10	20	52	55	0	0	0	0	0	0	0	58.77	0	0	11.4	0.3	3.6
2025	4	10	21	2	55	0	0	0	0	0	0	0	58.66	0	0	11.4	0.3	3.6
2025	4	10	21	12	55	0	0	0	0	0	0	0	58.57	0	0	11.4	0.3	3.6
2025	4	10	21	22	55	0	0	0	0	0	0	0	58.48	0	0	11.4	0.3	3.6
2025	4	10	21	32	55	0	0	0	0	0	0	0	58.39	0	0	11.4	0.3	3.6
2025	4	10	21	42	55	0	0	0	0	0	0	0	58.3	0	0	11.4	0.3	3.6
2025	4	10	21	52	55	0	0	0	0	0	0	0	58.21	0	0	11.4	0.3	3.6
2025	4	10	22	2	55	0	0	0	0	0	0	0	58.12	0	0	11.4	0.3	3.6
2025	4	10	22	12	55	0	0	0	0	0	0	0	58.03	0	0	11.4	0.3	3.6
2025	4	10	22	22	55	0	0	0	0	0	0	0	57.96	0	0	11.4	0.3	3.6
2025	4	10	22	32	55	0	0	0	0	0	0	0	57.87	0	0	11.4	0.3	3.6
2025	4	10	22	42	55	0	0	0	0	0	0	0	57.76	0	0	11.4	0.3	3.6
2025	4	10	22	52	55	0	0	0	0	0	0	0	57.67	0	0	11.4	0.3	3.6
2025	4	10	23	2	55	0	0	0	0	0	0	0	57.58	0	0	11.4	0.3	3.6
2025	4	10	23	12	55	0	0	0	0	0	0	0	57.49	0	0	11.4	0.3	3.6
2025	4	10	23	22	55	0	0	0	0	0	0	0	57.4	0	0	11.4	0.3	3.6
2025	4	10	23	32	55	0	0	0	0	0	0	0	57.31	0	0	11.4	0.3	3.6
2025	4	10	23	42	55	0	0	0	0	0	0	0	57.22	0	0	11.4	0.3	3.6
2025	4	10	23	52	55	0	0	0	0	0	0	0	57.15	0	0	11.4	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	11	0	2	55	0	0	0	0	0	0	0	57.06	0	0	11.4	0.3	3.6
2025	4	11	0	12	55	0	0	0	0	0	0	0	56.98	0	0	11.2	0.3	3.6
2025	4	11	0	22	55	0	0	0	0	0	0	0	56.91	0	0	11.2	0.3	3.6
2025	4	11	0	32	55	0	0	0	0	0	0	0	56.84	0	0	11.2	0.3	3.6
2025	4	11	0	42	55	0	0	0	0	0	0	0	56.79	0	0	11.2	0.3	3.6
2025	4	11	0	52	55	0	0	0	0	0	0	0	56.73	0	0	11.2	0.3	3.6
2025	4	11	1	2	55	0	0	0	0	0	0	0	56.66	0	0	11.2	0.3	3.6
2025	4	11	1	12	55	0	0	0	0	0	0	0	56.62	0	0	11.2	0.3	3.6
2025	4	11	1	22	55	0	0	0	0	0	0	0	56.55	0	0	11.2	0.3	3.6
2025	4	11	1	32	55	0	0	0	0	0	0	0	56.52	0	0	11.2	0.3	3.6
2025	4	11	1	42	55	0	0	0	0	0	0	0	56.48	0	0	11.2	0.3	3.6
2025	4	11	1	52	55	0	0	0	0	0	0	0	56.44	0	0	11.2	0.3	3.6
2025	4	11	2	2	55	0	0	0	0	0	0	0	56.41	0	0	11.2	0.3	3.6
2025	4	11	2	12	55	0	0	0	0	0	0	0	56.37	0	0	11.2	0.3	3.6
2025	4	11	2	22	55	0	0	0	0	0	0	0	56.35	0	0	11.2	0.3	3.6
2025	4	11	2	32	55	0	0	0	0	0	0	0	56.32	0	0	11.2	0.3	3.6
2025	4	11	2	42	55	0	0	0	0	0	0	0	56.3	0	0	11.2	0.3	3.6
2025	4	11	2	52	55	0	0	0	0	0	0	0	56.28	0	0	11.2	0.3	3.6
2025	4	11	3	2	55	0	0	0	0	0	0	0	56.26	0	0	11.2	0.3	3.6
2025	4	11	3	12	55	0	0	0	0	0	0	0	56.25	0	0	11.2	0.3	3.6
2025	4	11	3	22	55	0	0	0	0	0	0	0	56.25	0	0	11.2	0.3	3.6
2025	4	11	3	32	55	0	0	0	0	0	0	0	56.23	0	0	11.2	0.3	3.6
2025	4	11	3	42	55	0	0	0	0	0	0	0	56.23	0	0	11.2	0.3	3.6
2025	4	11	3	52	55	0	0	0	0	0	0	0	56.21	0	0	11.2	0.3	3.6
2025	4	11	4	2	55	0	0	0	0	0	0	0	56.21	0	0	11.2	0.3	3.6
2025	4	11	4	12	55	0	0	0	0	0	0	0	56.21	0	0	11.2	0.3	3.6
2025	4	11	4	22	55	0	0	0	0	0	0	0	56.23	0	0	11.2	0.3	3.6
2025	4	11	4	32	55	0	0	0	0	0	0	0	56.23	0	0	11.2	0.3	3.6
2025	4	11	4	42	55	0	0	0	0	0	0	0	56.23	0	0	11.2	0.3	3.6
2025	4	11	4	52	55	0	0	0	0	0	0	0	56.23	0	0	11.2	0.3	3.6
2025	4	11	5	2	55	0	0	0	0	0	0	0	56.23	0	0	11.2	0.3	3.6
2025	4	11	5	12	55	0	0	0	0	0	0	0	56.25	0	0	11.2	0.3	3.6
2025	4	11	5	22	55	0	0	0	0	0	0	0	56.25	0	0	11.2	0.3	3.6
2025	4	11	5	32	55	0	0	0	0	0	0	0	56.26	0	0	11.2	0.3	3.6
2025	4	11	5	42	55	0	0	0	0	0	0	0	56.25	0	0	11.2	0.3	3.6
2025	4	11	5	52	55	0	0	0	0	0	0	0	56.28	0	0	11.2	0.3	3.6
2025	4	11	6	2	55	0	0	0	0	0	0	0	56.28	0	0	11.2	0.3	3.6
2025	4	11	6	12	55	0	0	0	0	0	0	0	56.3	0	0	11.2	0.3	3.6
2025	4	11	6	22	55	0	0	0	0	0	0	0	56.3	0	0	11.4	0.3	3.6
2025	4	11	6	32	55	0	0	0	0	0	0	0	56.34	0	0	11.6	0.3	3.6
2025	4	11	6	42	55	0	0	0	0	0	0	0	56.35	0	0	11.8	0.3	3.6
2025	4	11	6	52	55	0	0	0	0	0	0	0	56.41	0	0	12	0.3	3.6
2025	4	11	7	2	55	0	0	0	0	0	0	0	56.46	0	0	12.2	0.3	3.6
2025	4	11	7	12	55	0	0	0	0	0	0	0	56.5	0	0	12.2	0.3	3.6
2025	4	11	7	22	55	0	0	0	0	0	0	0	56.59	0	0	12.4	0.3	3.6
2025	4	11	7	32	55	0	0	0	0	0	0	0	56.7	0	0	12.4	0.3	3.6
2025	4	11	7	42	55	0	0	0	0	0	0	0	56.77	0	0	12.6	0.3	3.6
2025	4	11	7	52	55	0	0	0	0	0	0	0	56.86	0	0	12.6	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	11	8	2	55	0	0	0	0	0	0	0	56.97	0	0	12.8	0.3	3.6
2025	4	11	8	12	55	0	0	0	0	0	0	0	57.04	0	0	12.8	0.3	3.6
2025	4	11	8	22	55	0	0	0	0	0	0	0	57.15	0	0	13.2	0.3	3.6
2025	4	11	8	32	55	0	0	0	0	0	0	0	57.25	0	0	13.6	0.3	3.6
2025	4	11	8	42	55	0	0	0	0	0	0	0	57.38	0	0	13.6	0.3	3.6
2025	4	11	8	52	55	0	0	0	0	0	0	0	57.47	0	0	13.4	0.3	3.6
2025	4	11	9	2	55	0	0	0	0	0	0	0	57.6	0	0	13.2	0.3	3.6
2025	4	11	9	12	55	0	0	0	0	0	0	0	57.7	0	0	13.2	0.3	3.6
2025	4	11	9	22	55	0	0	0	0	0	0	0	57.83	0	0	13.2	0.3	3.6
2025	4	11	9	32	55	0	0	0	0	0	0	0	57.94	0	0	13.2	0.3	3.6
2025	4	11	9	42	55	0	0	0	0	0	0	0	58.05	0	0	13.4	0.3	3.6
2025	4	11	9	52	55	0	0	0	0	0	0	0	58.15	0	0	13.4	0.3	3.6
2025	4	11	10	2	55	0	0	0	0	0	0	0	58.28	0	0	13.2	0.3	3.6
2025	4	11	10	12	55	0	0	0	0	0	0	0	58.41	0	0	13.2	0.3	3.6
2025	4	11	10	22	55	0	0	0	0	0	0	0	58.57	0	0	13	0.3	3.6
2025	4	11	10	32	55	0	0	0	0	0	0	0	58.69	0	0	13.2	0.3	3.6
2025	4	11	10	42	55	0	0	0	0	0	0	0	58.8	0	0	13.2	0.3	3.6
2025	4	11	10	52	55	0	0	0	0	0	0	0	58.95	0	0	13.2	0.3	3.6
2025	4	11	11	2	55	0	0	0	0	0	0	0	59.09	0	0	13	0.3	3.6
2025	4	11	11	12	55	0	0	0	0	0	0	0	59.2	0	0	12.8	0.3	3.6
2025	4	11	11	22	55	0	0	0	0	0	0	0	59.31	0	0	13	0.3	3.6
2025	4	11	11	32	55	0	0	0	0	0	0	0	59.45	0	0	12.8	0.3	3.6
2025	4	11	11	42	55	0	0	0	0	0	0	0	59.58	0	0	12.8	0.3	3.6
2025	4	11	11	52	55	0	0	0	0	0	0	0	59.67	0	0	12.8	0.3	3.6
2025	4	11	12	2	55	0	0	0	0	0	0	0	59.85	0	0	12.8	0.3	3.6
2025	4	11	12	12	55	0	0	0	0	0	0	0	59.94	0	0	13	0.3	3.6
2025	4	11	12	22	55	0	0	0	0	0	0	0	60.03	0	0	13	0.3	3.6
2025	4	11	12	32	55	0	0	0	0	0	0	0	60.17	0	0	12.8	0.3	3.6
2025	4	11	12	42	55	0	0	0	0	0	0	0	60.24	0	0	12.8	0.3	3.6
2025	4	11	12	52	55	0	0	0	0	0	0	0	60.35	0	0	12.8	0.3	3.6
2025	4	11	13	2	55	0	0	0	0	0	0	0	60.46	0	0	12.6	0.3	3.6
2025	4	11	13	12	55	0	0	0	0	0	0	0	60.55	0	0	12.6	0.3	3.6
2025	4	11	13	22	55	0	0	0	0	0	0	0	60.64	0	0	12.6	0.3	3.6
2025	4	11	13	32	55	0	0	0	0	0	0	0	60.75	0	0	12.6	0.3	3.6
2025	4	11	13	42	55	0	0	0	0	0	0	0	60.82	0	0	12.6	0.3	3.6
2025	4	11	13	52	55	0	0	0	0	0	0	0	60.91	0	0	12.8	0.3	3.6
2025	4	11	14	2	55	0	0	0	0	0	0	0	60.98	0	0	12.8	0.3	3.6
2025	4	11	14	12	55	0	0	0	0	0	0	0	61.03	0	0	13	0.3	3.6
2025	4	11	14	22	55	0	0	0	0	0	0	0	61.11	0	0	12.8	0.3	3.6
2025	4	11	14	32	55	0	0	0	0	0	0	0	61.16	0	0	12.6	0.3	3.6
2025	4	11	14	42	55	0	0	0	0	0	0	0	61.2	0	0	12.8	0.3	3.6
2025	4	11	14	52	55	0	0	0	0	0	0	0	61.27	0	0	12.8	0.3	3.6
2025	4	11	15	2	55	0	0	0	0	0	0	0	61.3	0	0	12.6	0.3	3.6
2025	4	11	15	12	55	0	0	0	0	0	0	0	61.29	0	0	11.6	0.3	3.6
2025	4	11	15	22	55	0	0	0	0	0	0	0	61.36	0	0	12.8	0.3	3.6
2025	4	11	15	32	55	0	0	0	0	0	0	0	61.38	0	0	11.6	0.3	3.6
2025	4	11	15	42	55	0	0	0	0	0	0	0	61.41	0	0	11.2	0.3	3.6
2025	4	11	15	52	55	0	0	0	0	0	0	0	61.41	0	0	12	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	11	16	2	55	0	0	0	0	0	0	0	61.41	0	0	12.6	0.3	3.6
2025	4	11	16	12	55	0	0	0	0	0	0	0	61.41	0	0	12.4	0.3	3.6
2025	4	11	16	22	55	0	0	0	0	0	0	0	61.39	0	0	12.2	0.3	3.6
2025	4	11	16	32	55	0	0	0	0	0	0	0	61.38	0	0	12	0.3	3.6
2025	4	11	16	42	55	0	0	0	0	0	0	0	61.34	0	0	11.8	0.3	3.6
2025	4	11	16	52	55	0	0	0	0	0	0	0	61.3	0	0	11.8	0.3	3.6
2025	4	11	17	2	55	0	0	0	0	0	0	0	61.25	0	0	11.6	0.3	3.6
2025	4	11	17	12	55	0	0	0	0	0	0	0	61.18	0	0	11.6	0.3	3.6
2025	4	11	17	22	55	0	0	0	0	0	0	0	61.14	0	0	11.6	0.3	3.6
2025	4	11	17	32	55	0	0	0	0	0	0	0	61.07	0	0	11.6	0.3	3.6
2025	4	11	17	42	55	0	0	0	0	0	0	0	61.03	0	0	11.6	0.3	3.6
2025	4	11	17	52	55	0	0	0	0	0	0	0	60.96	0	0	11.6	0.3	3.6
2025	4	11	18	2	55	0	0	0	0	0	0	0	60.91	0	0	11.4	0.3	3.6
2025	4	11	18	12	55	0	0	0	0	0	0	0	60.84	0	0	11.4	0.3	3.6
2025	4	11	18	22	55	0	0	0	0	0	0	0	60.76	0	0	11.4	0.3	3.6
2025	4	11	18	32	55	0	0	0	0	0	0	0	60.69	0	0	11.4	0.3	3.6
2025	4	11	18	42	55	0	0	0	0	0	0	0	60.64	0	0	11.4	0.3	3.6
2025	4	11	18	52	55	0	0	0	0	0	0	0	60.57	0	0	11.4	0.3	3.6
2025	4	11	19	2	55	0	0	0	0	0	0	0	60.48	0	0	11.4	0.3	3.6
2025	4	11	19	12	55	0	0	0	0	0	0	0	60.4	0	0	11.4	0.3	3.6
2025	4	11	19	22	55	0	0	0	0	0	0	0	60.33	0	0	11.4	0.3	3.6
2025	4	11	19	32	55	0	0	0	0	0	0	0	60.22	0	0	11.4	0.3	3.6
2025	4	11	19	42	55	0	0	0	0	0	0	0	60.13	0	0	11.2	0.3	3.6
2025	4	11	19	52	55	0	0	0	0	0	0	0	60.04	0	0	10.8	0.3	3.6
2025	4	11	20	2	55	0	0	0	0	0	0	0	59.95	0	0	10.8	0.3	3.6
2025	4	11	20	12	55	0	0	0	0	0	0	0	59.85	0	0	10.8	0.3	3.6
2025	4	11	20	22	55	0	0	0	0	0	0	0	59.76	0	0	10.8	0.3	3.6
2025	4	11	20	32	55	0	0	0	0	0	0	0	59.67	0	0	10.6	0.3	3.6
2025	4	11	20	42	55	0	0	0	0	0	0	0	59.56	0	0	10.6	0.3	3.6
2025	4	11	20	52	55	0	0	0	0	0	0	0	59.47	0	0	11.2	0.3	3.6
2025	4	11	21	2	55	0	0	0	0	0	0	0	59.38	0	0	11.2	0.3	3.6
2025	4	11	21	12	55	0	0	0	0	0	0	0	59.29	0	0	10.8	0.3	3.6
2025	4	11	21	22	55	0	0	0	0	0	0	0	59.18	0	0	10.6	0.3	3.6
2025	4	11	21	32	55	0	0	0	0	0	0	0	59.09	0	0	11.2	0.3	3.6
2025	4	11	21	42	55	0	0	0	0	0	0	0	59.02	0	0	11	0.3	3.6
2025	4	11	21	52	55	0	0	0	0	0	0	0	58.93	0	0	10.4	0.3	3.6
2025	4	11	22	2	55	0	0	0	0	0	0	0	58.84	0	0	11	0.3	3.6
2025	4	11	22	12	55	0	0	0	0	0	0	0	58.75	0	0	10.8	0.3	3.6
2025	4	11	22	22	55	0	0	0	0	0	0	0	58.68	0	0	11	0.3	3.6
2025	4	11	22	32	55	0	0	0	0	0	0	0	58.59	0	0	10.8	0.3	3.6
2025	4	11	22	42	55	0	0	0	0	0	0	0	58.51	0	0	10.8	0.3	3.6
2025	4	11	22	52	55	0	0	0	0	0	0	0	58.44	0	0	10.6	0.3	3.6
2025	4	11	23	2	55	0	0	0	0	0	0	0	58.37	0	0	10.4	0.3	3.6
2025	4	11	23	12	55	0	0	0	0	0	0	0	58.3	0	0	10.2	0.3	3.6
2025	4	11	23	22	55	0	0	0	0	0	0	0	58.23	0	0	11	0.3	3.6
2025	4	11	23	32	55	0	0	0	0	0	0	0	58.15	0	0	11.2	0.3	3.6
2025	4	11	23	42	55	0	0	0	0	0	0	0	58.1	0	0	11.2	0.3	3.6
2025	4	11	23	52	55	0	0	0	0	0	0	0	58.05	0	0	11	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	12	0	2	55	0	0	0	0	0	0	0	57.97	0	0	11	0.3	3.6
2025	4	12	0	12	55	0	0	0	0	0	0	0	57.92	0	0	11	0.3	3.6
2025	4	12	0	22	55	0	0	0	0	0	0	0	57.88	0	0	11	0.3	3.6
2025	4	12	0	32	55	0	0	0	0	0	0	0	57.83	0	0	11	0.3	3.6
2025	4	12	0	42	55	0	0	0	0	0	0	0	57.79	0	0	11	0.3	3.6
2025	4	12	0	52	55	0	0	0	0	0	0	0	57.76	0	0	11	0.3	3.6
2025	4	12	1	2	55	0	0	0	0	0	0	0	57.74	0	0	11	0.3	3.6
2025	4	12	1	12	55	0	0	0	0	0	0	0	57.69	0	0	11	0.3	3.6
2025	4	12	1	22	55	0	0	0	0	0	0	0	57.67	0	0	11	0.3	3.6
2025	4	12	1	32	55	0	0	0	0	0	0	0	57.63	0	0	11	0.3	3.6
2025	4	12	1	42	55	0	0	0	0	0	0	0	57.61	0	0	11	0.3	3.6
2025	4	12	1	52	55	0	0	0	0	0	0	0	57.6	0	0	11	0.3	3.6
2025	4	12	2	2	55	0	0	0	0	0	0	0	57.56	0	0	11	0.3	3.6
2025	4	12	2	12	55	0	0	0	0	0	0	0	57.54	0	0	11	0.3	3.6
2025	4	12	2	22	55	0	0	0	0	0	0	0	57.54	0	0	11	0.3	3.6
2025	4	12	2	32	55	0	0	0	0	0	0	0	57.52	0	0	10.6	0.3	3.6
2025	4	12	2	42	55	0	0	0	0	0	0	0	57.52	0	0	10.6	0.3	3.6
2025	4	12	2	52	55	0	0	0	0	0	0	0	57.51	0	0	10.6	0.3	3.6
2025	4	12	3	2	55	0	0	0	0	0	0	0	57.51	0	0	10.6	0.3	3.6
2025	4	12	3	12	55	0	0	0	0	0	0	0	57.51	0	0	10.6	0.3	3.6
2025	4	12	3	22	55	0	0	0	0	0	0	0	57.49	0	0	10.8	0.3	3.6
2025	4	12	3	32	55	0	0	0	0	0	0	0	57.47	0	0	10.8	0.3	3.6
2025	4	12	3	42	55	0	0	0	0	0	0	0	57.49	0	0	10.8	0.3	3.6
2025	4	12	3	52	55	0	0	0	0	0	0	0	57.47	0	0	10.8	0.3	3.6
2025	4	12	4	2	55	0	0	0	0	0	0	0	57.47	0	0	10.8	0.3	3.6
2025	4	12	4	12	55	0	0	0	0	0	0	0	57.45	0	0	10.8	0.3	3.6
2025	4	12	4	22	55	0	0	0	0	0	0	0	57.45	0	0	10.8	0.3	3.6
2025	4	12	4	32	55	0	0	0	0	0	0	0	57.45	0	0	10.8	0.3	3.6
2025	4	12	4	42	55	0	0	0	0	0	0	0	57.43	0	0	10.6	0.3	3.6
2025	4	12	4	52	55	0	0	0	0	0	0	0	57.43	0	0	10.6	0.3	3.6
2025	4	12	5	2	55	0	0	0	0	0	0	0	57.43	0	0	10.6	0.3	3.6
2025	4	12	5	12	55	0	0	0	0	0	0	0	57.42	0	0	10.4	0.3	3.6
2025	4	12	5	22	55	0	0	0	0	0	0	0	57.4	0	0	10.6	0.3	3.6
2025	4	12	5	32	55	0	0	0	0	0	0	0	57.4	0	0	10.6	0.3	3.6
2025	4	12	5	42	55	0	0	0	0	0	0	0	57.38	0	0	10.6	0.3	3.6
2025	4	12	5	52	55	0	0	0	0	0	0	0	57.38	0	0	10.6	0.3	3.6
2025	4	12	6	2	55	0	0	0	0	0	0	0	57.38	0	0	10.6	0.3	3.6
2025	4	12	6	12	55	0	0	0	0	0	0	0	57.38	0	0	10.6	0.3	3.6
2025	4	12	6	22	55	0	0	0	0	0	0	0	57.38	0	0	10.8	0.3	3.6
2025	4	12	6	32	55	0	0	0	0	0	0	0	57.38	0	0	10.6	0.3	3.6
2025	4	12	6	42	55	0	0	0	0	0	0	0	57.4	0	0	10.6	0.3	3.6
2025	4	12	6	52	55	0	0	0	0	0	0	0	57.43	0	0	11.2	0.3	3.6
2025	4	12	7	2	55	0	0	0	0	0	0	0	57.45	0	0	11.4	0.3	3.6
2025	4	12	7	12	55	0	0	0	0	0	0	0	57.49	0	0	11.4	0.3	3.6
2025	4	12	7	22	55	0	0	0	0	0	0	0	57.56	0	0	11.6	0.3	3.6
2025	4	12	7	32	55	0	0	0	0	0	0	0	57.63	0	0	11.6	0.3	3.6
2025	4	12	7	42	55	0	0	0	0	0	0	0	57.72	0	0	11.6	0.3	3.6
2025	4	12	7	52	55	0	0	0	0	0	0	0	57.79	0	0	12.2	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	12	8	2	55	0	0	0	0	0	0	0	57.88	0	0	12.2	0.3	3.6
2025	4	12	8	12	55	0	0	0	0	0	0	0	57.96	0	0	13.4	0.3	3.6
2025	4	12	8	22	55	0	0	0	0	0	0	0	58.06	0	0	13.4	0.3	3.6
2025	4	12	8	32	55	0	0	0	0	0	0	0	58.15	0	0	13.6	0.3	3.6
2025	4	12	8	42	55	0	0	0	0	0	0	0	58.26	0	0	13.6	0.3	3.6
2025	4	12	8	52	55	0	0	0	0	0	0	0	58.37	0	0	13.2	0.3	3.6
2025	4	12	9	2	55	0	0	0	0	0	0	0	58.46	0	0	13.2	0.3	3.6
2025	4	12	9	12	55	0	0	0	0	0	0	0	58.57	0	0	13.2	0.3	3.6
2025	4	12	9	22	55	0	0	0	0	0	0	0	58.68	0	0	13.2	0.3	3.6
2025	4	12	9	32	55	0	0	0	0	0	0	0	58.77	0	0	13.2	0.3	3.6
2025	4	12	9	42	55	0	0	0	0	0	0	0	58.86	0	0	13.2	0.3	3.6
2025	4	12	9	52	55	0	0	0	0	0	0	0	58.96	0	0	13.2	0.3	3.6
2025	4	12	10	2	55	0	0	0	0	0	0	0	59.07	0	0	13	0.3	3.6
2025	4	12	10	12	55	0	0	0	0	0	0	0	59.2	0	0	13	0.3	3.6
2025	4	12	10	22	55	0	0	0	0	0	0	0	59.31	0	0	13.2	0.3	3.6
2025	4	12	10	32	55	0	0	0	0	0	0	0	59.43	0	0	13.4	0.3	3.6
2025	4	12	10	42	55	0	0	0	0	0	0	0	59.56	0	0	13.4	0.3	3.6
2025	4	12	10	52	55	0	0	0	0	0	0	0	59.68	0	0	13.4	0.3	3.6
2025	4	12	11	2	55	0	0	0	0	0	0	0	59.77	0	0	13.4	0.3	3.6
2025	4	12	11	12	55	0	0	0	0	0	0	0	59.88	0	0	13.4	0.3	3.6
2025	4	12	11	22	55	0	0	0	0	0	0	0	59.99	0	0	13.4	0.3	3.6
2025	4	12	11	32	55	0	0	0	0	0	0	0	60.1	0	0	13.4	0.3	3.6
2025	4	12	11	42	55	0	0	0	0	0	0	0	60.22	0	0	13.4	0.3	3.6
2025	4	12	11	52	55	0	0	0	0	0	0	0	60.33	0	0	13.4	0.3	3.6
2025	4	12	12	2	55	0	0	0	0	0	0	0	60.46	0	0	13.6	0.3	3.6
2025	4	12	12	12	55	0	0	0	0	0	0	0	60.57	0	0	13.6	0.3	3.6
2025	4	12	12	22	55	0	0	0	0	0	0	0	60.66	0	0	13.4	0.3	3.6
2025	4	12	12	32	55	0	0	0	0	0	0	0	60.73	0	0	13.4	0.3	3.6
2025	4	12	12	42	55	0	0	0	0	0	0	0	60.82	0	0	13.4	0.3	3.6
2025	4	12	12	52	55	0	0	0	0	0	0	0	60.91	0	0	13.4	0.3	3.6
2025	4	12	13	2	55	0	0	0	0	0	0	0	61	0	0	13.4	0.3	3.6
2025	4	12	13	12	55	0	0	0	0	0	0	0	61.09	0	0	13.4	0.3	3.6
2025	4	12	13	22	55	0	0	0	0	0	0	0	61.18	0	0	13.6	0.3	3.6
2025	4	12	13	32	55	0	0	0	0	0	0	0	61.23	0	0	13.6	0.3	3.6
2025	4	12	13	42	55	0	0	0	0	0	0	0	61.29	0	0	13.6	0.3	3.6
2025	4	12	13	52	55	0	0	0	0	0	0	0	61.38	0	0	13.6	0.3	3.6
2025	4	12	14	2	55	0	0	0	0	0	0	0	61.43	0	0	13.4	0.3	3.6
2025	4	12	14	12	55	0	0	0	0	0	0	0	61.48	0	0	13	0.3	3.6
2025	4	12	14	22	55	0	0	0	0	0	0	0	61.54	0	0	12.8	0.3	3.6
2025	4	12	14	32	55	0	0	0	0	0	0	0	61.56	0	0	12.8	0.3	3.6
2025	4	12	14	42	55	0	0	0	0	0	0	0	61.61	0	0	12.8	0.3	3.6
2025	4	12	14	52	55	0	0	0	0	0	0	0	61.65	0	0	12.6	0.3	3.6
2025	4	12	15	2	55	0	0	0	0	0	0	0	61.66	0	0	12.6	0.3	3.6
2025	4	12	15	12	55	0	0	0	0	0	0	0	61.66	0	0	12.4	0.3	3.6
2025	4	12	15	22	55	0	0	0	0	0	0	0	61.66	0	0	12.4	0.3	3.6
2025	4	12	15	32	55	0	0	0	0	0	0	0	61.63	0	0	11.8	0.3	3.6
2025	4	12	15	42	55	0	0	0	0	0	0	0	61.63	0	0	11.2	0.3	3.6
2025	4	12	15	52	55	0	0	0	0	0	0	0	61.61	0	0	10.8	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	12	16	2	55	0	0	0	0	0	0	0	61.59	0	0	10.4	0.3	3.6
2025	4	12	16	12	55	0	0	0	0	0	0	0	61.57	0	0	10.6	0.3	3.6
2025	4	12	16	22	55	0	0	0	0	0	0	0	61.56	0	0	10.2	0.3	3.6
2025	4	12	16	32	55	0	0	0	0	0	0	0	61.52	0	0	11.6	0.3	3.6
2025	4	12	16	42	55	0	0	0	0	0	0	0	61.48	0	0	11.8	0.3	3.6
2025	4	12	16	52	55	0	0	0	0	0	0	0	61.43	0	0	11.8	0.3	3.6
2025	4	12	17	2	55	0	0	0	0	0	0	0	61.36	0	0	11.6	0.3	3.6
2025	4	12	17	12	55	0	0	0	0	0	0	0	61.3	0	0	11.6	0.3	3.6
2025	4	12	17	22	55	0	0	0	0	0	0	0	61.23	0	0	11.6	0.3	3.6
2025	4	12	17	32	55	0	0	0	0	0	0	0	61.16	0	0	11.6	0.3	3.6
2025	4	12	17	42	55	0	0	0	0	0	0	0	61.07	0	0	11.4	0.3	3.6
2025	4	12	17	52	55	0	0	0	0	0	0	0	60.98	0	0	11.4	0.3	3.6
2025	4	12	18	2	55	0	0	0	0	0	0	0	60.91	0	0	11.4	0.3	3.6
2025	4	12	18	12	55	0	0	0	0	0	0	0	60.82	0	0	11.4	0.3	3.6
2025	4	12	18	22	55	0	0	0	0	0	0	0	60.73	0	0	11.4	0.3	3.6
2025	4	12	18	32	55	0	0	0	0	0	0	0	60.66	0	0	11.4	0.3	3.6
2025	4	12	18	42	55	0	0	0	0	0	0	0	60.57	0	0	11.4	0.3	3.6
2025	4	12	18	52	55	0	0	0	0	0	0	0	60.49	0	0	11.4	0.3	3.6
2025	4	12	19	2	55	0	0	0	0	0	0	0	60.42	0	0	11.4	0.3	3.6
2025	4	12	19	12	55	0	0	0	0	0	0	0	60.31	0	0	11.4	0.3	3.6
2025	4	12	19	22	55	0	0	0	0	0	0	0	60.22	0	0	11.4	0.3	3.6
2025	4	12	19	32	55	0	0	0	0	0	0	0	60.12	0	0	11.4	0.3	3.6
2025	4	12	19	42	55	0	0	0	0	0	0	0	60.01	0	0	11.4	0.3	3.6
2025	4	12	19	52	55	0	0	0	0	0	0	0	59.9	0	0	11.4	0.3	3.6
2025	4	12	20	2	55	0	0	0	0	0	0	0	59.79	0	0	11.4	0.3	3.6
2025	4	12	20	12	55	0	0	0	0	0	0	0	59.68	0	0	11.4	0.3	3.6
2025	4	12	20	22	55	0	0	0	0	0	0	0	59.56	0	0	11.4	0.3	3.6
2025	4	12	20	32	55	0	0	0	0	0	0	0	59.45	0	0	11.4	0.3	3.6
2025	4	12	20	42	55	0	0	0	0	0	0	0	59.34	0	0	11.4	0.3	3.6
2025	4	12	20	52	55	0	0	0	0	0	0	0	59.23	0	0	11.4	0.3	3.6
2025	4	12	21	2	55	0	0	0	0	0	0	0	59.16	0	0	11.4	0.3	3.6
2025	4	12	21	12	55	0	0	0	0	0	0	0	59.05	0	0	11.4	0.3	3.6
2025	4	12	21	22	55	0	0	0	0	0	0	0	58.96	0	0	11.4	0.3	3.6
2025	4	12	21	32	55	0	0	0	0	0	0	0	58.89	0	0	11.4	0.3	3.6
2025	4	12	21	42	55	0	0	0	0	0	0	0	58.8	0	0	11.4	0.3	3.6
2025	4	12	21	52	55	0	0	0	0	0	0	0	58.73	0	0	11.4	0.3	3.6
2025	4	12	22	2	55	0	0	0	0	0	0	0	58.64	0	0	11.4	0.3	3.6
2025	4	12	22	12	55	0	0	0	0	0	0	0	58.57	0	0	11.4	0.3	3.6
2025	4	12	22	22	55	0	0	0	0	0	0	0	58.5	0	0	11.4	0.3	3.6
2025	4	12	22	32	55	0	0	0	0	0	0	0	58.42	0	0	11.4	0.3	3.6
2025	4	12	22	42	55	0	0	0	0	0	0	0	58.37	0	0	11.4	0.3	3.6
2025	4	12	22	52	55	0	0	0	0	0	0	0	58.32	0	0	11.4	0.3	3.6
2025	4	12	23	2	55	0	0	0	0	0	0	0	58.26	0	0	11.4	0.3	3.6
2025	4	12	23	12	55	0	0	0	0	0	0	0	58.21	0	0	11.4	0.3	3.6
2025	4	12	23	22	55	0	0	0	0	0	0	0	58.17	0	0	11.4	0.3	3.6
2025	4	12	23	32	55	0	0	0	0	0	0	0	58.12	0	0	11.4	0.3	3.6
2025	4	12	23	42	55	0	0	0	0	0	0	0	58.08	0	0	11.4	0.3	3.6
2025	4	12	23	52	55	0	0	0	0	0	0	0	58.03	0	0	11.4	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	13	0	2	55	0	0	0	0	0	0	0	57.99	0	0	11.4	0.3	3.6
2025	4	13	0	12	55	0	0	0	0	0	0	0	57.94	0	0	11.2	0.3	3.6
2025	4	13	0	22	55	0	0	0	0	0	0	0	57.9	0	0	11.2	0.3	3.6
2025	4	13	0	32	55	0	0	0	0	0	0	0	57.88	0	0	11.2	0.3	3.6
2025	4	13	0	42	55	0	0	0	0	0	0	0	57.85	0	0	11.2	0.3	3.6
2025	4	13	0	52	55	0	0	0	0	0	0	0	57.83	0	0	11.4	0.3	3.6
2025	4	13	1	2	55	0	0	0	0	0	0	0	57.79	0	0	11.4	0.3	3.6
2025	4	13	1	12	55	0	0	0	0	0	0	0	57.78	0	0	11.4	0.3	3.6
2025	4	13	1	22	55	0	0	0	0	0	0	0	57.78	0	0	11.4	0.3	3.6
2025	4	13	1	32	55	0	0	0	0	0	0	0	57.76	0	0	11.4	0.3	3.6
2025	4	13	1	42	55	0	0	0	0	0	0	0	57.76	0	0	11.4	0.3	3.6
2025	4	13	1	52	55	0	0	0	0	0	0	0	57.74	0	0	11.4	0.3	3.6
2025	4	13	2	2	55	0	0	0	0	0	0	0	57.74	0	0	11.4	0.3	3.6
2025	4	13	2	12	55	0	0	0	0	0	0	0	57.74	0	0	11.4	0.3	3.6
2025	4	13	2	22	55	0	0	0	0	0	0	0	57.74	0	0	11.2	0.3	3.6
2025	4	13	2	32	55	0	0	0	0	0	0	0	57.74	0	0	11.2	0.3	3.6
2025	4	13	2	42	55	0	0	0	0	0	0	0	57.72	0	0	11.2	0.3	3.6
2025	4	13	2	52	55	0	0	0	0	0	0	0	57.72	0	0	11.2	0.3	3.6
2025	4	13	3	2	55	0	0	0	0	0	0	0	57.72	0	0	11.2	0.3	3.6
2025	4	13	3	12	55	0	0	0	0	0	0	0	57.74	0	0	11.2	0.3	3.6
2025	4	13	3	22	55	0	0	0	0	0	0	0	57.74	0	0	11.2	0.3	3.6
2025	4	13	3	32	55	0	0	0	0	0	0	0	57.74	0	0	11.2	0.3	3.6
2025	4	13	3	42	55	0	0	0	0	0	0	0	57.74	0	0	11.2	0.3	3.6
2025	4	13	3	52	55	0	0	0	0	0	0	0	57.76	0	0	11.2	0.3	3.6
2025	4	13	4	2	55	0	0	0	0	0	0	0	57.76	0	0	11.2	0.3	3.6
2025	4	13	4	12	55	0	0	0	0	0	0	0	57.78	0	0	11.2	0.3	3.6
2025	4	13	4	22	55	0	0	0	0	0	0	0	57.78	0	0	11.2	0.3	3.6
2025	4	13	4	32	55	0	0	0	0	0	0	0	57.78	0	0	11.2	0.3	3.6
2025	4	13	4	42	55	0	0	0	0	0	0	0	57.79	0	0	11.2	0.3	3.6
2025	4	13	4	52	55	0	0	0	0	0	0	0	57.79	0	0	11.2	0.3	3.6
2025	4	13	5	2	55	0	0	0	0	0	0	0	57.81	0	0	11.2	0.3	3.6
2025	4	13	5	12	55	0	0	0	0	0	0	0	57.83	0	0	11.2	0.3	3.6
2025	4	13	5	22	55	0	0	0	0	0	0	0	57.83	0	0	11.2	0.3	3.6
2025	4	13	5	32	55	0	0	0	0	0	0	0	57.85	0	0	11.2	0.3	3.6
2025	4	13	5	42	55	0	0	0	0	0	0	0	57.87	0	0	11.2	0.3	3.6
2025	4	13	5	52	55	0	0	0	0	0	0	0	57.9	0	0	11.2	0.3	3.6
2025	4	13	6	2	55	0	0	0	0	0	0	0	57.94	0	0	11.2	0.3	3.6
2025	4	13	6	12	55	0	0	0	0	0	0	0	57.96	0	0	11.4	0.3	3.6
2025	4	13	6	22	55	0	0	0	0	0	0	0	57.99	0	0	11.4	0.3	3.6
2025	4	13	6	32	55	0	0	0	0	0	0	0	58.03	0	0	11.6	0.3	3.6
2025	4	13	6	42	55	0	0	0	0	0	0	0	58.05	0	0	11.8	0.3	3.6
2025	4	13	6	52	55	0	0	0	0	0	0	0	58.08	0	0	12	0.3	3.6
2025	4	13	7	2	55	0	0	0	0	0	0	0	58.1	0	0	12	0.3	3.6
2025	4	13	7	12	55	0	0	0	0	0	0	0	58.14	0	0	12.2	0.3	3.6
2025	4	13	7	22	55	0	0	0	0	0	0	0	58.15	0	0	12.2	0.3	3.6
2025	4	13	7	32	55	0	0	0	0	0	0	0	58.21	0	0	12.4	0.3	3.6
2025	4	13	7	42	55	0	0	0	0	0	0	0	58.26	0	0	12.4	0.3	3.6
2025	4	13	7	52	55	0	0	0	0	0	0	0	58.28	0	0	13	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	13	8	2	55	0	0	0	0	0	0	0	58.32	0	0	13.2	0.3	3.6
2025	4	13	8	12	55	0	0	0	0	0	0	0	58.37	0	0	13.4	0.3	3.6
2025	4	13	8	22	55	0	0	0	0	0	0	0	58.42	0	0	13.4	0.3	3.6
2025	4	13	8	32	55	0	0	0	0	0	0	0	58.5	0	0	13.6	0.3	3.6
2025	4	13	8	42	55	0	0	0	0	0	0	0	58.55	0	0	13.6	0.3	3.6
2025	4	13	8	52	55	0	0	0	0	0	0	0	58.62	0	0	13.6	0.3	3.6
2025	4	13	9	2	55	0	0	0	0	0	0	0	58.71	0	0	13.6	0.3	3.6
2025	4	13	9	12	55	0	0	0	0	0	0	0	58.77	0	0	13.6	0.3	3.6
2025	4	13	9	22	55	0	0	0	0	0	0	0	58.84	0	0	13.6	0.3	3.6
2025	4	13	9	32	55	0	0	0	0	0	0	0	58.93	0	0	13.6	0.3	3.6
2025	4	13	9	42	55	0	0	0	0	0	0	0	59	0	0	13.6	0.3	3.6
2025	4	13	9	52	55	0	0	0	0	0	0	0	59.07	0	0	13.6	0.3	3.6
2025	4	13	10	2	55	0	0	0	0	0	0	0	59.16	0	0	13.6	0.3	3.6
2025	4	13	10	12	55	0	0	0	0	0	0	0	59.27	0	0	13.6	0.3	3.6
2025	4	13	10	22	55	0	0	0	0	0	0	0	59.34	0	0	13.6	0.3	3.6
2025	4	13	10	32	55	0	0	0	0	0	0	0	59.45	0	0	13.6	0.3	3.6
2025	4	13	10	42	55	0	0	0	0	0	0	0	59.56	0	0	13.6	0.3	3.6
2025	4	13	10	52	55	0	0	0	0	0	0	0	59.63	0	0	13.6	0.3	3.6
2025	4	13	11	2	55	0	0	0	0	0	0	0	59.74	0	0	13.4	0.3	3.6
2025	4	13	11	12	55	0	0	0	0	0	0	0	59.83	0	0	13.4	0.3	3.6
2025	4	13	11	22	55	0	0	0	0	0	0	0	59.92	0	0	13.2	0.3	3.6
2025	4	13	11	32	55	0	0	0	0	0	0	0	60.01	0	0	13.2	0.3	3.6
2025	4	13	11	42	55	0	0	0	0	0	0	0	60.08	0	0	13.2	0.3	3.6
2025	4	13	11	52	55	0	0	0	0	0	0	0	60.19	0	0	13.2	0.3	3.6
2025	4	13	12	2	55	0	0	0	0	0	0	0	60.26	0	0	13.2	0.3	3.6
2025	4	13	12	12	55	0	0	0	0	0	0	0	60.33	0	0	13.2	0.3	3.6
2025	4	13	12	22	55	0	0	0	0	0	0	0	60.4	0	0	13.2	0.3	3.6
2025	4	13	12	32	55	0	0	0	0	0	0	0	60.48	0	0	13.4	0.3	3.6
2025	4	13	12	42	55	0	0	0	0	0	0	0	60.55	0	0	13.2	0.3	3.6
2025	4	13	12	52	55	0	0	0	0	0	0	0	60.55	0	0	13.2	0.3	3.6
2025	4	13	13	2	55	0	0	0	0	0	0	0	60.4	0	0	13.2	0.3	3.6
2025	4	13	13	12	55	0	0	0	0	0	0	0	60.49	0	0	13.4	0.3	3.6
2025	4	13	13	22	55	0	0	0	0	0	0	0	60.46	0	0	13.2	0.3	3.6
2025	4	13	13	32	55	0	0	0	0	0	0	0	60.4	0	0	13.2	0.3	3.6
2025	4	13	13	42	55	0	0	0	0	0	0	0	60.58	0	0	13.4	0.3	3.6
2025	4	13	13	52	55	0	0	0	0	0	0	0	60.57	0	0	13.4	0.3	3.6
2025	4	13	14	2	55	0	0	0	0	0	0	0	60.57	0	0	13.4	0.3	3.6
2025	4	13	14	12	55	0	0	0	0	0	0	0	60.57	0	0	13.4	0.3	3.6
2025	4	13	14	22	55	0	0	0	0	0	0	0	60.58	0	0	13.2	0.3	3.6
2025	4	13	14	32	55	0	0	0	0	0	0	0	60.57	0	0	13.2	0.3	3.6
2025	4	13	14	42	55	0	0	0	0	0	0	0	60.58	0	0	13.4	0.3	3.6
2025	4	13	14	52	55	0	0	0	0	0	0	0	60.58	0	0	13.4	0.3	3.6
2025	4	13	15	2	55	0	0	0	0	0	0	0	60.57	0	0	13	0.3	3.6
2025	4	13	15	12	55	0	0	0	0	0	0	0	60.57	0	0	13.4	0.3	3.6
2025	4	13	15	22	55	0	0	0	0	0	0	0	60.58	0	0	12.6	0.3	3.6
2025	4	13	15	32	55	0	0	0	0	0	0	0	60.57	0	0	12.6	0.3	3.6
2025	4	13	15	42	55	0	0	0	0	0	0	0	60.57	0	0	12.6	0.3	3.6
2025	4	13	15	52	55	0	0	0	0	0	0	0	60.55	0	0	12.4	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	13	16	2	55	0	0	0	0	0	0	0	60.55	0	0	12.4	0.3	3.6
2025	4	13	16	12	55	0	0	0	0	0	0	0	60.53	0	0	12.4	0.3	3.6
2025	4	13	16	22	55	0	0	0	0	0	0	0	60.51	0	0	12.4	0.3	3.6
2025	4	13	16	32	55	0	0	0	0	0	0	0	60.49	0	0	12.2	0.3	3.6
2025	4	13	16	42	55	0	0	0	0	0	0	0	60.48	0	0	12.2	0.3	3.6
2025	4	13	16	52	55	0	0	0	0	0	0	0	60.44	0	0	12	0.3	3.6
2025	4	13	17	2	55	0	0	0	0	0	0	0	60.39	0	0	11.8	0.3	3.6
2025	4	13	17	12	55	0	0	0	0	0	0	0	60.35	0	0	11.8	0.3	3.6
2025	4	13	17	22	55	0	0	0	0	0	0	0	60.31	0	0	11.8	0.3	3.6
2025	4	13	17	32	55	0	0	0	0	0	0	0	60.28	0	0	11.8	0.3	3.6
2025	4	13	17	42	55	0	0	0	0	0	0	0	60.22	0	0	11.8	0.3	3.6
2025	4	13	17	52	55	0	0	0	0	0	0	0	60.17	0	0	11.8	0.3	3.6
2025	4	13	18	2	55	0	0	0	0	0	0	0	60.1	0	0	11.8	0.3	3.6
2025	4	13	18	12	55	0	0	0	0	0	0	0	60.03	0	0	11.6	0.3	3.6
2025	4	13	18	22	55	0	0	0	0	0	0	0	59.95	0	0	11.6	0.3	3.6
2025	4	13	18	32	55	0	0	0	0	0	0	0	59.88	0	0	11.6	0.3	3.6
2025	4	13	18	42	55	0	0	0	0	0	0	0	59.79	0	0	11.6	0.3	3.6
2025	4	13	18	52	55	0	0	0	0	0	0	0	59.7	0	0	11.6	0.3	3.6
2025	4	13	19	2	55	0	0	0	0	0	0	0	59.61	0	0	11.6	0.3	3.6
2025	4	13	19	12	55	0	0	0	0	0	0	0	59.52	0	0	11.6	0.3	3.6
2025	4	13	19	22	55	0	0	0	0	0	0	0	59.43	0	0	11.6	0.3	3.6
2025	4	13	19	32	55	0	0	0	0	0	0	0	59.34	0	0	11.6	0.3	3.6
2025	4	13	19	42	55	0	0	0	0	0	0	0	59.25	0	0	11.6	0.3	3.6
2025	4	13	19	52	55	0	0	0	0	0	0	0	59.14	0	0	11.6	0.3	3.6
2025	4	13	20	2	55	0	0	0	0	0	0	0	59.05	0	0	11.6	0.3	3.6
2025	4	13	20	12	55	0	0	0	0	0	0	0	58.96	0	0	11.6	0.3	3.6
2025	4	13	20	22	55	0	0	0	0	0	0	0	58.87	0	0	11.6	0.3	3.6
2025	4	13	20	32	55	0	0	0	0	0	0	0	58.78	0	0	11.6	0.3	3.6
2025	4	13	20	42	55	0	0	0	0	0	0	0	58.69	0	0	11.6	0.3	3.6
2025	4	13	20	52	55	0	0	0	0	0	0	0	58.6	0	0	11.6	0.3	3.6
2025	4	13	21	2	55	0	0	0	0	0	0	0	58.51	0	0	11.6	0.3	3.6
2025	4	13	21	12	55	0	0	0	0	0	0	0	58.42	0	0	11.6	0.3	3.6
2025	4	13	21	22	55	0	0	0	0	0	0	0	58.33	0	0	11.6	0.3	3.6
2025	4	13	21	32	55	0	0	0	0	0	0	0	58.24	0	0	11.6	0.3	3.6
2025	4	13	21	42	55	0	0	0	0	0	0	0	58.17	0	0	11.6	0.3	3.6
2025	4	13	21	52	55	0	0	0	0	0	0	0	58.08	0	0	11.6	0.3	3.6
2025	4	13	22	2	55	0	0	0	0	0	0	0	58.01	0	0	11.6	0.3	3.6
2025	4	13	22	12	55	0	0	0	0	0	0	0	57.94	0	0	11.6	0.3	3.6
2025	4	13	22	22	55	0	0	0	0	0	0	0	57.83	0	0	11.6	0.3	3.6
2025	4	13	22	32	55	0	0	0	0	0	0	0	57.76	0	0	11.6	0.3	3.6
2025	4	13	22	42	55	0	0	0	0	0	0	0	57.7	0	0	11.6	0.3	3.6
2025	4	13	22	52	55	0	0	0	0	0	0	0	57.63	0	0	11.6	0.3	3.6
2025	4	13	23	2	55	0	0	0	0	0	0	0	57.58	0	0	11.6	0.3	3.6
2025	4	13	23	12	55	0	0	0	0	0	0	0	57.52	0	0	11.6	0.3	3.6
2025	4	13	23	22	55	0	0	0	0	0	0	0	57.45	0	0	11.6	0.3	3.6
2025	4	13	23	32	55	0	0	0	0	0	0	0	57.42	0	0	11.6	0.3	3.6
2025	4	13	23	42	55	0	0	0	0	0	0	0	57.36	0	0	11.6	0.3	3.6
2025	4	13	23	52	55	0	0	0	0	0	0	0	57.31	0	0	11.6	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	14	0	2	55	0	0	0	0	0	0	0	57.27	0	0	11.6	0.3	3.6
2025	4	14	0	12	55	0	0	0	0	0	0	0	57.24	0	0	11.6	0.3	3.6
2025	4	14	0	22	55	0	0	0	0	0	0	0	57.2	0	0	11.6	0.3	3.6
2025	4	14	0	32	55	0	0	0	0	0	0	0	57.16	0	0	11.6	0.3	3.6
2025	4	14	0	42	55	0	0	0	0	0	0	0	57.13	0	0	11.6	0.3	3.6
2025	4	14	0	52	55	0	0	0	0	0	0	0	57.11	0	0	11.6	0.3	3.6
2025	4	14	1	2	55	0	0	0	0	0	0	0	57.07	0	0	11.6	0.3	3.6
2025	4	14	1	12	55	0	0	0	0	0	0	0	57.04	0	0	11.6	0.3	3.6
2025	4	14	1	22	55	0	0	0	0	0	0	0	57.02	0	0	11.6	0.3	3.6
2025	4	14	1	32	55	0	0	0	0	0	0	0	57	0	0	11.6	0.3	3.6
2025	4	14	1	42	55	0	0	0	0	0	0	0	56.98	0	0	11.6	0.3	3.6
2025	4	14	1	52	55	0	0	0	0	0	0	0	56.97	0	0	11.6	0.3	3.6
2025	4	14	2	2	55	0	0	0	0	0	0	0	56.95	0	0	11.6	0.3	3.6
2025	4	14	2	12	55	0	0	0	0	0	0	0	56.95	0	0	11.6	0.3	3.6
2025	4	14	2	22	55	0	0	0	0	0	0	0	56.93	0	0	11.6	0.3	3.6
2025	4	14	2	32	55	0	0	0	0	0	0	0	56.91	0	0	11.4	0.3	3.6
2025	4	14	2	42	55	0	0	0	0	0	0	0	56.91	0	0	11.4	0.3	3.6
2025	4	14	2	52	55	0	0	0	0	0	0	0	56.89	0	0	11.4	0.3	3.6
2025	4	14	3	2	55	0	0	0	0	0	0	0	56.88	0	0	11.4	0.3	3.6
2025	4	14	3	12	55	0	0	0	0	0	0	0	56.88	0	0	11.4	0.3	3.6
2025	4	14	3	22	55	0	0	0	0	0	0	0	56.86	0	0	11.4	0.3	3.6
2025	4	14	3	32	55	0	0	0	0	0	0	0	56.86	0	0	11.4	0.3	3.6
2025	4	14	3	42	55	0	0	0	0	0	0	0	56.84	0	0	11.4	0.3	3.6
2025	4	14	3	52	55	0	0	0	0	0	0	0	56.84	0	0	11.4	0.3	3.6
2025	4	14	4	2	55	0	0	0	0	0	0	0	56.84	0	0	11.4	0.3	3.6
2025	4	14	4	12	55	0	0	0	0	0	0	0	56.84	0	0	11.4	0.3	3.6
2025	4	14	4	22	55	0	0	0	0	0	0	0	56.84	0	0	11.4	0.3	3.6
2025	4	14	4	32	55	0	0	0	0	0	0	0	56.84	0	0	11.4	0.3	3.6
2025	4	14	4	42	55	0	0	0	0	0	0	0	56.84	0	0	11.4	0.3	3.6
2025	4	14	4	52	55	0	0	0	0	0	0	0	56.84	0	0	11.4	0.3	3.6
2025	4	14	5	2	55	0	0	0	0	0	0	0	56.84	0	0	11.4	0.3	3.6
2025	4	14	5	12	55	0	0	0	0	0	0	0	56.84	0	0	11.4	0.3	3.6
2025	4	14	5	22	55	0	0	0	0	0	0	0	56.86	0	0	11.4	0.3	3.6
2025	4	14	5	32	55	0	0	0	0	0	0	0	56.84	0	0	11.4	0.3	3.6
2025	4	14	5	42	55	0	0	0	0	0	0	0	56.86	0	0	11.4	0.3	3.6
2025	4	14	5	52	55	0	0	0	0	0	0	0	56.88	0	0	11.4	0.3	3.6
2025	4	14	6	2	55	0	0	0	0	0	0	0	56.86	0	0	11.4	0.3	3.6
2025	4	14	6	12	55	0	0	0	0	0	0	0	56.88	0	0	11.6	0.3	3.6
2025	4	14	6	22	55	0	0	0	0	0	0	0	56.88	0	0	11.8	0.3	3.6
2025	4	14	6	32	55	0	0	0	0	0	0	0	56.91	0	0	12	0.3	3.6
2025	4	14	6	42	55	0	0	0	0	0	0	0	56.93	0	0	12	0.3	3.6
2025	4	14	6	52	55	0	0	0	0	0	0	0	56.97	0	0	12.2	0.3	3.6
2025	4	14	7	2	55	0	0	0	0	0	0	0	57	0	0	12.4	0.3	3.6
2025	4	14	7	12	55	0	0	0	0	0	0	0	57.06	0	0	12.6	0.3	3.6
2025	4	14	7	22	55	0	0	0	0	0	0	0	57.11	0	0	12.6	0.3	3.6
2025	4	14	7	32	55	0	0	0	0	0	0	0	57.2	0	0	13	0.3	3.6
2025	4	14	7	42	55	0	0	0	0	0	0	0	57.27	0	0	13.2	0.3	3.6
2025	4	14	7	52	55	0	0	0	0	0	0	0	57.34	0	0	13.4	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	14	8	2	55	0	0	0	0	0	0	0	57.43	0	0	13.6	0.3	3.6
2025	4	14	8	12	55	0	0	0	0	0	0	0	57.49	0	0	13.6	0.3	3.6
2025	4	14	8	22	55	0	0	0	0	0	0	0	57.58	0	0	13.6	0.3	3.6
2025	4	14	8	32	55	0	0	0	0	0	0	0	57.67	0	0	13.6	0.3	3.6
2025	4	14	8	42	55	0	0	0	0	0	0	0	57.78	0	0	13.4	0.3	3.6
2025	4	14	8	52	55	0	0	0	0	0	0	0	57.87	0	0	13.4	0.3	3.6
2025	4	14	9	2	55	0	0	0	0	0	0	0	57.96	0	0	13.6	0.3	3.6
2025	4	14	9	12	55	0	0	0	0	0	0	0	58.05	0	0	13.4	0.3	3.6
2025	4	14	9	22	55	0	0	0	0	0	0	0	58.1	0	0	13.4	0.3	3.6
2025	4	14	9	32	55	0	0	0	0	0	0	0	58.19	0	0	13.4	0.3	3.6
2025	4	14	9	42	55	0	0	0	0	0	0	0	58.33	0	0	13.4	0.3	3.6
2025	4	14	9	52	55	0	0	0	0	0	0	0	58.35	0	0	13.4	0.3	3.6
2025	4	14	10	2	55	0	0	0	0	0	0	0	58.39	0	0	13.4	0.3	3.6
2025	4	14	10	12	55	0	0	0	0	0	0	0	58.5	0	0	13.4	0.3	3.6
2025	4	14	10	22	55	0	0	0	0	0	0	0	58.55	0	0	13.4	0.3	3.6
2025	4	14	10	32	55	0	0	0	0	0	0	0	58.62	0	0	13.4	0.3	3.6
2025	4	14	10	42	55	0	0	0	0	0	0	0	58.73	0	0	13.4	0.3	3.6
2025	4	14	10	52	55	0	0	0	0	0	0	0	58.8	0	0	13.4	0.3	3.6
2025	4	14	11	2	55	0	0	0	0	0	0	0	58.95	0	0	13.4	0.3	3.6
2025	4	14	11	12	55	0	0	0	0	0	0	0	59.05	0	0	13.4	0.3	3.6
2025	4	14	11	22	55	0	0	0	0	0	0	0	59.09	0	0	13.6	0.3	3.6
2025	4	14	11	32	55	0	0	0	0	0	0	0	59.09	0	0	13.6	0.3	3.6
2025	4	14	11	42	55	0	0	0	0	0	0	0	59.2	0	0	13.6	0.3	3.6
2025	4	14	11	52	55	0	0	0	0	0	0	0	59.29	0	0	13.8	0.3	3.6
2025	4	14	12	2	55	0	0	0	0	0	0	0	59.45	0	0	13.6	0.3	3.6
2025	4	14	12	12	55	0	0	0	0	0	0	0	59.5	0	0	13.6	0.3	3.6
2025	4	14	12	22	55	0	0	0	0	0	0	0	59.61	0	0	13.6	0.3	3.6
2025	4	14	12	32	55	0	0	0	0	0	0	0	59.67	0	0	13.6	0.3	3.6
2025	4	14	12	42	55	0	0	0	0	0	0	0	59.67	0	0	13.6	0.3	3.6
2025	4	14	12	52	55	0	0	0	0	0	0	0	59.68	0	0	13.6	0.3	3.6
2025	4	14	13	2	55	0	0	0	0	0	0	0	59.76	0	0	13.6	0.3	3.6
2025	4	14	13	12	55	0	0	0	0	0	0	0	59.88	0	0	13.6	0.3	3.6
2025	4	14	13	22	55	0	0	0	0	0	0	0	60.01	0	0	13.4	0.3	3.6
2025	4	14	13	32	55	0	0	0	0	0	0	0	60.06	0	0	13.4	0.3	3.6
2025	4	14	13	42	55	0	0	0	0	0	0	0	60.15	0	0	13.4	0.3	3.6
2025	4	14	13	52	55	0	0	0	0	0	0	0	60.15	0	0	13.6	0.3	3.6
2025	4	14	14	2	55	0	0	0	0	0	0	0	60.24	0	0	13.4	0.3	3.6
2025	4	14	14	12	55	0	0	0	0	0	0	0	60.28	0	0	13.6	0.3	3.6
2025	4	14	14	22	55	0	0	0	0	0	0	0	60.31	0	0	13.6	0.3	3.6
2025	4	14	14	32	55	0	0	0	0	0	0	0	60.35	0	0	13.6	0.3	3.6
2025	4	14	14	42	55	0	0	0	0	0	0	0	60.35	0	0	13.6	0.3	3.6
2025	4	14	14	52	55	0	0	0	0	0	0	0	60.37	0	0	13.6	0.3	3.6
2025	4	14	15	2	55	0	0	0	0	0	0	0	60.39	0	0	13.6	0.3	3.6
2025	4	14	15	12	55	0	0	0	0	0	0	0	60.39	0	0	13.6	0.3	3.6
2025	4	14	15	22	55	0	0	0	0	0	0	0	60.39	0	0	13.4	0.3	3.6
2025	4	14	15	32	55	0	0	0	0	0	0	0	60.35	0	0	13.4	0.3	3.6
2025	4	14	15	42	55	0	0	0	0	0	0	0	60.35	0	0	13.4	0.3	3.6
2025	4	14	15	52	55	0	0	0	0	0	0	0	60.35	0	0	13.4	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	14	16	2	55	0	0	0	0	0	0	0	60.33	0	0	13.2	0.3	3.6
2025	4	14	16	12	55	0	0	0	0	0	0	0	60.28	0	0	12.6	0.3	3.6
2025	4	14	16	22	55	0	0	0	0	0	0	0	60.24	0	0	12.4	0.3	3.6
2025	4	14	16	32	55	0	0	0	0	0	0	0	60.21	0	0	12.4	0.3	3.6
2025	4	14	16	42	55	0	0	0	0	0	0	0	60.17	0	0	12.2	0.3	3.6
2025	4	14	16	52	55	0	0	0	0	0	0	0	60.12	0	0	12	0.3	3.6
2025	4	14	17	2	55	0	0	0	0	0	0	0	60.06	0	0	12	0.3	3.6
2025	4	14	17	12	55	0	0	0	0	0	0	0	60.01	0	0	11.8	0.3	3.6
2025	4	14	17	22	55	0	0	0	0	0	0	0	59.95	0	0	11.8	0.3	3.6
2025	4	14	17	32	55	0	0	0	0	0	0	0	59.9	0	0	11.8	0.3	3.6
2025	4	14	17	42	55	0	0	0	0	0	0	0	59.85	0	0	11.8	0.3	3.6
2025	4	14	17	52	55	0	0	0	0	0	0	0	59.79	0	0	11.6	0.3	3.6
2025	4	14	18	2	55	0	0	0	0	0	0	0	59.72	0	0	11.6	0.3	3.6
2025	4	14	18	12	55	0	0	0	0	0	0	0	59.67	0	0	11.6	0.3	3.6
2025	4	14	18	22	55	0	0	0	0	0	0	0	59.59	0	0	11.6	0.3	3.6
2025	4	14	18	32	55	0	0	0	0	0	0	0	59.5	0	0	11.6	0.3	3.6
2025	4	14	18	42	55	0	0	0	0	0	0	0	59.43	0	0	11.6	0.3	3.6
2025	4	14	18	52	55	0	0	0	0	0	0	0	59.36	0	0	11.6	0.3	3.6
2025	4	14	19	2	55	0	0	0	0	0	0	0	59.27	0	0	11.6	0.3	3.6
2025	4	14	19	12	55	0	0	0	0	0	0	0	59.18	0	0	11.6	0.3	3.6
2025	4	14	19	22	55	0	0	0	0	0	0	0	59.11	0	0	11.6	0.3	3.6
2025	4	14	19	32	55	0	0	0	0	0	0	0	59.02	0	0	11.6	0.3	3.6
2025	4	14	19	42	55	0	0	0	0	0	0	0	58.95	0	0	11.6	0.3	3.6
2025	4	14	19	52	55	0	0	0	0	0	0	0	58.84	0	0	11.6	0.3	3.6
2025	4	14	20	2	55	0	0	0	0	0	0	0	58.77	0	0	11.6	0.3	3.6
2025	4	14	20	12	55	0	0	0	0	0	0	0	58.69	0	0	11.6	0.3	3.6
2025	4	14	20	22	55	0	0	0	0	0	0	0	58.6	0	0	11.6	0.3	3.6
2025	4	14	20	32	55	0	0	0	0	0	0	0	58.53	0	0	11.6	0.3	3.6
2025	4	14	20	42	55	0	0	0	0	0	0	0	58.46	0	0	11.6	0.3	3.6
2025	4	14	20	52	55	0	0	0	0	0	0	0	58.39	0	0	11.6	0.3	3.6
2025	4	14	21	2	55	0	0	0	0	0	0	0	58.3	0	0	11.6	0.3	3.6
2025	4	14	21	12	55	0	0	0	0	0	0	0	58.23	0	0	11.6	0.3	3.6
2025	4	14	21	22	55	0	0	0	0	0	0	0	58.15	0	0	11.6	0.3	3.6
2025	4	14	21	32	55	0	0	0	0	0	0	0	58.08	0	0	11.6	0.3	3.6
2025	4	14	21	42	55	0	0	0	0	0	0	0	58.03	0	0	11.6	0.3	3.6
2025	4	14	21	52	55	0	0	0	0	0	0	0	57.97	0	0	11.6	0.3	3.6
2025	4	14	22	2	55	0	0	0	0	0	0	0	57.9	0	0	11.6	0.3	3.6
2025	4	14	22	12	55	0	0	0	0	0	0	0	57.85	0	0	11.6	0.3	3.6
2025	4	14	22	22	55	0	0	0	0	0	0	0	57.79	0	0	11.6	0.3	3.6
2025	4	14	22	32	55	0	0	0	0	0	0	0	57.74	0	0	11.6	0.3	3.6
2025	4	14	22	42	55	0	0	0	0	0	0	0	57.67	0	0	11.6	0.3	3.6
2025	4	14	22	52	55	0	0	0	0	0	0	0	57.63	0	0	11.6	0.3	3.6
2025	4	14	23	2	55	0	0	0	0	0	0	0	57.56	0	0	11.6	0.3	3.6
2025	4	14	23	12	55	0	0	0	0	0	0	0	57.51	0	0	11.6	0.3	3.6
2025	4	14	23	22	55	0	0	0	0	0	0	0	57.45	0	0	11.6	0.3	3.6
2025	4	14	23	32	55	0	0	0	0	0	0	0	57.4	0	0	11.6	0.3	3.6
2025	4	14	23	42	55	0	0	0	0	0	0	0	57.34	0	0	11.6	0.3	3.6
2025	4	14	23	52	55	0	0	0	0	0	0	0	57.29	0	0	11.6	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	15	0	2	55	0	0	0	0	0	0	0	57.24	0	0	11.6	0.3	3.6
2025	4	15	0	12	55	0	0	0	0	0	0	0	57.2	0	0	11.6	0.3	3.6
2025	4	15	0	22	55	0	0	0	0	0	0	0	57.15	0	0	11.6	0.3	3.6
2025	4	15	0	32	55	0	0	0	0	0	0	0	57.11	0	0	11.6	0.3	3.6
2025	4	15	0	42	55	0	0	0	0	0	0	0	57.07	0	0	11.6	0.3	3.6
2025	4	15	0	52	55	0	0	0	0	0	0	0	57.04	0	0	11.6	0.3	3.6
2025	4	15	1	2	55	0	0	0	0	0	0	0	57	0	0	11.6	0.3	3.6
2025	4	15	1	12	55	0	0	0	0	0	0	0	56.98	0	0	11.4	0.3	3.6
2025	4	15	1	22	55	0	0	0	0	0	0	0	56.95	0	0	11.4	0.3	3.6
2025	4	15	1	32	55	0	0	0	0	0	0	0	56.93	0	0	11.4	0.3	3.6
2025	4	15	1	42	55	0	0	0	0	0	0	0	56.91	0	0	11.4	0.3	3.6
2025	4	15	1	52	55	0	0	0	0	0	0	0	56.91	0	0	11.4	0.3	3.6
2025	4	15	2	2	55	0	0	0	0	0	0	0	56.89	0	0	11.4	0.3	3.6
2025	4	15	2	12	55	0	0	0	0	0	0	0	56.88	0	0	11.4	0.3	3.6
2025	4	15	2	22	55	0	0	0	0	0	0	0	56.88	0	0	11.4	0.3	3.6
2025	4	15	2	32	55	0	0	0	0	0	0	0	56.86	0	0	11.4	0.3	3.6
2025	4	15	2	42	55	0	0	0	0	0	0	0	56.84	0	0	11.4	0.3	3.6
2025	4	15	2	52	55	0	0	0	0	0	0	0	56.84	0	0	11.4	0.3	3.6
2025	4	15	3	2	55	0	0	0	0	0	0	0	56.82	0	0	11.4	0.3	3.6
2025	4	15	3	12	55	0	0	0	0	0	0	0	56.82	0	0	11.4	0.3	3.6
2025	4	15	3	22	55	0	0	0	0	0	0	0	56.82	0	0	11.4	0.3	3.6
2025	4	15	3	32	55	0	0	0	0	0	0	0	56.82	0	0	11.4	0.3	3.6
2025	4	15	3	42	55	0	0	0	0	0	0	0	56.82	0	0	11.4	0.3	3.6
2025	4	15	3	52	55	0	0	0	0	0	0	0	56.82	0	0	11.4	0.3	3.6
2025	4	15	4	2	55	0	0	0	0	0	0	0	56.82	0	0	11.4	0.3	3.6
2025	4	15	4	12	55	0	0	0	0	0	0	0	56.82	0	0	11.4	0.3	3.6
2025	4	15	4	22	55	0	0	0	0	0	0	0	56.82	0	0	11.4	0.3	3.6
2025	4	15	4	32	55	0	0	0	0	0	0	0	56.8	0	0	11.4	0.3	3.6
2025	4	15	4	42	55	0	0	0	0	0	0	0	56.82	0	0	11.4	0.3	3.6
2025	4	15	4	52	55	0	0	0	0	0	0	0	56.82	0	0	11.4	0.3	3.6
2025	4	15	5	2	55	0	0	0	0	0	0	0	56.8	0	0	11.4	0.3	3.6
2025	4	15	5	12	55	0	0	0	0	0	0	0	56.8	0	0	11.4	0.3	3.6
2025	4	15	5	22	55	0	0	0	0	0	0	0	56.82	0	0	11.4	0.3	3.6
2025	4	15	5	32	55	0	0	0	0	0	0	0	56.8	0	0	11.4	0.3	3.6
2025	4	15	5	42	55	0	0	0	0	0	0	0	56.82	0	0	11.4	0.3	3.6
2025	4	15	5	52	55	0	0	0	0	0	0	0	56.82	0	0	11.4	0.3	3.6
2025	4	15	6	2	55	0	0	0	0	0	0	0	56.82	0	0	11.4	0.3	3.6
2025	4	15	6	12	55	0	0	0	0	0	0	0	56.84	0	0	11.6	0.3	3.6
2025	4	15	6	22	55	0	0	0	0	0	0	0	56.84	0	0	11.8	0.3	3.6
2025	4	15	6	32	55	0	0	0	0	0	0	0	56.86	0	0	11.8	0.3	3.6
2025	4	15	6	42	55	0	0	0	0	0	0	0	56.88	0	0	12.2	0.3	3.6
2025	4	15	6	52	55	0	0	0	0	0	0	0	56.91	0	0	12.4	0.3	3.6
2025	4	15	7	2	55	0	0	0	0	0	0	0	56.95	0	0	12.6	0.3	3.6
2025	4	15	7	12	55	0	0	0	0	0	0	0	57	0	0	12.6	0.3	3.6
2025	4	15	7	22	55	0	0	0	0	0	0	0	57.04	0	0	12.8	0.3	3.6
2025	4	15	7	32	55	0	0	0	0	0	0	0	57.15	0	0	12.8	0.3	3.6
2025	4	15	7	42	55	0	0	0	0	0	0	0	57.22	0	0	13.2	0.3	3.6
2025	4	15	7	52	55	0	0	0	0	0	0	0	57.29	0	0	13.6	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	15	8	2	55	0	0	0	0	0	0	0	57.38	0	0	13.6	0.3	3.6
2025	4	15	8	12	55	0	0	0	0	0	0	0	57.47	0	0	13.8	0.3	3.6
2025	4	15	8	22	55	0	0	0	0	0	0	0	57.54	0	0	13.8	0.3	3.6
2025	4	15	8	32	55	0	0	0	0	0	0	0	57.65	0	0	13.8	0.3	3.6
2025	4	15	8	42	55	0	0	0	0	0	0	0	57.76	0	0	13.8	0.3	3.6
2025	4	15	8	52	55	0	0	0	0	0	0	0	57.85	0	0	13.8	0.3	3.6
2025	4	15	9	2	55	0	0	0	0	0	0	0	57.94	0	0	13.8	0.3	3.6
2025	4	15	9	12	55	0	0	0	0	0	0	0	58.01	0	0	13.4	0.3	3.6
2025	4	15	9	22	55	0	0	0	0	0	0	0	58.12	0	0	13.4	0.3	3.6
2025	4	15	9	32	55	0	0	0	0	0	0	0	58.23	0	0	13.2	0.3	3.6
2025	4	15	9	42	55	0	0	0	0	0	0	0	58.33	0	0	13.6	0.3	3.6
2025	4	15	9	52	55	0	0	0	0	0	0	0	58.42	0	0	13.4	0.3	3.6
2025	4	15	10	2	55	0	0	0	0	0	0	0	58.53	0	0	13.2	0.3	3.6
2025	4	15	10	12	55	0	0	0	0	0	0	0	58.64	0	0	13.4	0.3	3.6
2025	4	15	10	22	55	0	0	0	0	0	0	0	58.73	0	0	13.2	0.3	3.6
2025	4	15	10	32	55	0	0	0	0	0	0	0	58.78	0	0	13.4	0.3	3.6
2025	4	15	10	42	55	0	0	0	0	0	0	0	58.91	0	0	13.2	0.3	3.6
2025	4	15	10	52	55	0	0	0	0	0	0	0	59.02	0	0	13.2	0.3	3.6
2025	4	15	11	2	55	0	0	0	0	0	0	0	59.13	0	0	13.2	0.3	3.6
2025	4	15	11	12	55	0	0	0	0	0	0	0	59.22	0	0	13.2	0.3	3.6
2025	4	15	11	22	55	0	0	0	0	0	0	0	59.18	0	0	13.4	0.3	3.6
2025	4	15	11	32	55	0	0	0	0	0	0	0	59.22	0	0	13.4	0.3	3.6
2025	4	15	11	42	55	0	0	0	0	0	0	0	59.34	0	0	13.2	0.3	3.6
2025	4	15	11	52	55	0	0	0	0	0	0	0	59.49	0	0	13.2	0.3	3.6
2025	4	15	12	2	55	0	0	0	0	0	0	0	59.54	0	0	13.2	0.3	3.6
2025	4	15	12	12	55	0	0	0	0	0	0	0	59.5	0	0	13.4	0.3	3.6
2025	4	15	12	22	55	0	0	0	0	0	0	0	59.63	0	0	13.2	0.3	3.6
2025	4	15	12	32	55	0	0	0	0	0	0	0	59.76	0	0	13.2	0.3	3.6
2025	4	15	12	42	55	0	0	0	0	0	0	0	59.83	0	0	13.2	0.3	3.6
2025	4	15	12	52	55	0	0	0	0	0	0	0	59.88	0	0	13.2	0.3	3.6
2025	4	15	13	2	55	0	0	0	0	0	0	0	59.9	0	0	13.4	0.3	3.6
2025	4	15	13	12	55	0	0	0	0	0	0	0	59.86	0	0	13.4	0.3	3.6
2025	4	15	13	22	55	0	0	0	0	0	0	0	60.01	0	0	13.2	0.3	3.6
2025	4	15	13	32	55	0	0	0	0	0	0	0	60.1	0	0	13.2	0.3	3.6
2025	4	15	13	42	55	0	0	0	0	0	0	0	60.19	0	0	13.2	0.3	3.6
2025	4	15	13	52	55	0	0	0	0	0	0	0	60.22	0	0	13.4	0.3	3.6
2025	4	15	14	2	55	0	0	0	0	0	0	0	60.26	0	0	13.6	0.3	3.6
2025	4	15	14	12	55	0	0	0	0	0	0	0	60.33	0	0	13.6	0.3	3.6
2025	4	15	14	22	55	0	0	0	0	0	0	0	60.37	0	0	13.6	0.3	3.6
2025	4	15	14	32	55	0	0	0	0	0	0	0	60.35	0	0	13.6	0.3	3.6
2025	4	15	14	42	55	0	0	0	0	0	0	0	60.33	0	0	13.6	0.3	3.6
2025	4	15	14	52	55	0	0	0	0	0	0	0	60.35	0	0	13.6	0.3	3.6
2025	4	15	15	2	55	0	0	0	0	0	0	0	60.31	0	0	13	0.3	3.6
2025	4	15	15	12	55	0	0	0	0	0	0	0	60.3	0	0	13.6	0.3	3.6
2025	4	15	15	22	55	0	0	0	0	0	0	0	60.28	0	0	13.4	0.3	3.6
2025	4	15	15	32	55	0	0	0	0	0	0	0	60.28	0	0	13.4	0.3	3.6
2025	4	15	15	42	55	0	0	0	0	0	0	0	60.26	0	0	13.2	0.3	3.6
2025	4	15	15	52	55	0	0	0	0	0	0	0	60.24	0	0	13	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	15	16	2	55	0	0	0	0	0	0	0	60.21	0	0	12.6	0.3	3.6
2025	4	15	16	12	55	0	0	0	0	0	0	0	60.17	0	0	12.6	0.3	3.6
2025	4	15	16	22	55	0	0	0	0	0	0	0	60.13	0	0	12.2	0.3	3.6
2025	4	15	16	32	55	0	0	0	0	0	0	0	60.06	0	0	12	0.3	3.6
2025	4	15	16	42	55	0	0	0	0	0	0	0	60.01	0	0	12	0.3	3.6
2025	4	15	16	52	55	0	0	0	0	0	0	0	59.95	0	0	11.8	0.3	3.6
2025	4	15	17	2	55	0	0	0	0	0	0	0	59.9	0	0	11.8	0.3	3.6
2025	4	15	17	12	55	0	0	0	0	0	0	0	59.85	0	0	11.8	0.3	3.6
2025	4	15	17	22	55	0	0	0	0	0	0	0	59.79	0	0	11.8	0.3	3.6
2025	4	15	17	32	55	0	0	0	0	0	0	0	59.74	0	0	11.8	0.3	3.6
2025	4	15	17	42	55	0	0	0	0	0	0	0	59.67	0	0	11.8	0.3	3.6
2025	4	15	17	52	55	0	0	0	0	0	0	0	59.59	0	0	11.6	0.3	3.6
2025	4	15	18	2	55	0	0	0	0	0	0	0	59.52	0	0	11.6	0.3	3.6
2025	4	15	18	12	55	0	0	0	0	0	0	0	59.43	0	0	11.6	0.3	3.6
2025	4	15	18	22	55	0	0	0	0	0	0	0	59.38	0	0	11.6	0.3	3.6
2025	4	15	18	32	55	0	0	0	0	0	0	0	59.29	0	0	11.6	0.3	3.6
2025	4	15	18	42	55	0	0	0	0	0	0	0	59.2	0	0	11.6	0.3	3.6
2025	4	15	18	52	55	0	0	0	0	0	0	0	59.13	0	0	11.6	0.3	3.6
2025	4	15	19	2	55	0	0	0	0	0	0	0	59.02	0	0	11.6	0.3	3.6
2025	4	15	19	12	55	0	0	0	0	0	0	0	58.95	0	0	11.6	0.3	3.6
2025	4	15	19	22	55	0	0	0	0	0	0	0	58.86	0	0	11.6	0.3	3.6
2025	4	15	19	32	55	0	0	0	0	0	0	0	58.77	0	0	11.6	0.3	3.6
2025	4	15	19	42	55	0	0	0	0	0	0	0	58.69	0	0	11.6	0.3	3.6
2025	4	15	19	52	55	0	0	0	0	0	0	0	58.6	0	0	11.6	0.3	3.6
2025	4	15	20	2	55	0	0	0	0	0	0	0	58.53	0	0	11.6	0.3	3.6
2025	4	15	20	12	55	0	0	0	0	0	0	0	58.42	0	0	11.6	0.3	3.6
2025	4	15	20	22	55	0	0	0	0	0	0	0	58.35	0	0	11.6	0.3	3.6
2025	4	15	20	32	55	0	0	0	0	0	0	0	58.26	0	0	11.6	0.3	3.6
2025	4	15	20	42	55	0	0	0	0	0	0	0	58.17	0	0	11.6	0.3	3.6
2025	4	15	20	52	55	0	0	0	0	0	0	0	58.1	0	0	11.6	0.3	3.6
2025	4	15	21	2	55	0	0	0	0	0	0	0	58.03	0	0	11.6	0.3	3.6
2025	4	15	21	12	55	0	0	0	0	0	0	0	57.96	0	0	11.6	0.3	3.6
2025	4	15	21	22	55	0	0	0	0	0	0	0	57.88	0	0	11.6	0.3	3.6
2025	4	15	21	32	55	0	0	0	0	0	0	0	57.83	0	0	11.6	0.3	3.6
2025	4	15	21	42	55	0	0	0	0	0	0	0	57.76	0	0	11.6	0.3	3.6
2025	4	15	21	52	55	0	0	0	0	0	0	0	57.7	0	0	11.6	0.3	3.6
2025	4	15	22	2	55	0	0	0	0	0	0	0	57.63	0	0	11.6	0.3	3.6
2025	4	15	22	12	55	0	0	0	0	0	0	0	57.58	0	0	11.6	0.3	3.6
2025	4	15	22	22	55	0	0	0	0	0	0	0	57.52	0	0	11.6	0.3	3.6
2025	4	15	22	32	55	0	0	0	0	0	0	0	57.47	0	0	11.6	0.3	3.6
2025	4	15	22	42	55	0	0	0	0	0	0	0	57.43	0	0	11.6	0.3	3.6
2025	4	15	22	52	55	0	0	0	0	0	0	0	57.38	0	0	11.6	0.3	3.6
2025	4	15	23	2	55	0	0	0	0	0	0	0	57.31	0	0	11.6	0.3	3.6
2025	4	15	23	12	55	0	0	0	0	0	0	0	57.25	0	0	11.6	0.3	3.6
2025	4	15	23	22	55	0	0	0	0	0	0	0	57.2	0	0	11.6	0.3	3.6
2025	4	15	23	32	55	0	0	0	0	0	0	0	57.16	0	0	11.6	0.3	3.6
2025	4	15	23	42	55	0	0	0	0	0	0	0	57.13	0	0	11.6	0.3	3.6
2025	4	15	23	52	55	0	0	0	0	0	0	0	57.07	0	0	11.6	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	16	0	2	55	0	0	0	0	0	0	0	57.02	0	0	11.6	0.3	3.6
2025	4	16	0	12	55	0	0	0	0	0	0	0	57	0	0	11.6	0.3	3.6
2025	4	16	0	22	55	0	0	0	0	0	0	0	56.97	0	0	11.6	0.3	3.6
2025	4	16	0	32	55	0	0	0	0	0	0	0	56.93	0	0	11.6	0.3	3.6
2025	4	16	0	42	55	0	0	0	0	0	0	0	56.91	0	0	11.6	0.3	3.6
2025	4	16	0	52	55	0	0	0	0	0	0	0	56.89	0	0	11.6	0.3	3.6
2025	4	16	1	2	55	0	0	0	0	0	0	0	56.88	0	0	11.6	0.3	3.6
2025	4	16	1	12	55	0	0	0	0	0	0	0	56.86	0	0	11.6	0.3	3.6
2025	4	16	1	22	55	0	0	0	0	0	0	0	56.86	0	0	11.6	0.3	3.6
2025	4	16	1	32	55	0	0	0	0	0	0	0	56.86	0	0	11.6	0.3	3.6
2025	4	16	1	42	55	0	0	0	0	0	0	0	56.84	0	0	11.6	0.3	3.6
2025	4	16	1	52	55	0	0	0	0	0	0	0	56.84	0	0	11.6	0.3	3.6
2025	4	16	2	2	55	0	0	0	0	0	0	0	56.84	0	0	11.6	0.3	3.6
2025	4	16	2	12	55	0	0	0	0	0	0	0	56.84	0	0	11.6	0.3	3.6
2025	4	16	2	22	55	0	0	0	0	0	0	0	56.84	0	0	11.6	0.3	3.6
2025	4	16	2	32	55	0	0	0	0	0	0	0	56.84	0	0	11.4	0.3	3.6
2025	4	16	2	42	55	0	0	0	0	0	0	0	56.84	0	0	11.4	0.3	3.6
2025	4	16	2	52	55	0	0	0	0	0	0	0	56.82	0	0	11.4	0.3	3.6
2025	4	16	3	2	55	0	0	0	0	0	0	0	56.84	0	0	11.4	0.3	3.6
2025	4	16	3	12	55	0	0	0	0	0	0	0	56.84	0	0	11.4	0.3	3.6
2025	4	16	3	22	55	0	0	0	0	0	0	0	56.84	0	0	11.4	0.3	3.6
2025	4	16	3	32	55	0	0	0	0	0	0	0	56.84	0	0	11.4	0.3	3.6
2025	4	16	3	42	55	0	0	0	0	0	0	0	56.86	0	0	11.4	0.3	3.6
2025	4	16	3	52	55	0	0	0	0	0	0	0	56.86	0	0	11.4	0.3	3.6
2025	4	16	4	2	55	0	0	0	0	0	0	0	56.86	0	0	11.4	0.3	3.6
2025	4	16	4	12	55	0	0	0	0	0	0	0	56.86	0	0	11.4	0.3	3.6
2025	4	16	4	22	55	0	0	0	0	0	0	0	56.88	0	0	11.4	0.3	3.6
2025	4	16	4	32	55	0	0	0	0	0	0	0	56.88	0	0	11.4	0.3	3.6
2025	4	16	4	42	55	0	0	0	0	0	0	0	56.88	0	0	11.4	0.3	3.6
2025	4	16	4	52	55	0	0	0	0	0	0	0	56.89	0	0	11.4	0.3	3.6
2025	4	16	5	2	55	0	0	0	0	0	0	0	56.91	0	0	11.4	0.3	3.6
2025	4	16	5	12	55	0	0	0	0	0	0	0	56.91	0	0	11.4	0.3	3.6
2025	4	16	5	22	55	0	0	0	0	0	0	0	56.93	0	0	11.4	0.3	3.6
2025	4	16	5	32	55	0	0	0	0	0	0	0	56.95	0	0	11.4	0.3	3.6
2025	4	16	5	42	55	0	0	0	0	0	0	0	56.97	0	0	11.4	0.3	3.6
2025	4	16	5	52	55	0	0	0	0	0	0	0	57	0	0	11.4	0.3	3.6
2025	4	16	6	2	55	0	0	0	0	0	0	0	57.02	0	0	11.4	0.3	3.6
2025	4	16	6	12	55	0	0	0	0	0	0	0	57.06	0	0	11.4	0.3	3.6
2025	4	16	6	22	55	0	0	0	0	0	0	0	57.07	0	0	11.4	0.3	3.6
2025	4	16	6	32	55	0	0	0	0	0	0	0	57.11	0	0	11.6	0.3	3.6
2025	4	16	6	42	55	0	0	0	0	0	0	0	57.15	0	0	11.6	0.3	3.6
2025	4	16	6	52	55	0	0	0	0	0	0	0	57.16	0	0	11.6	0.3	3.6
2025	4	16	7	2	55	0	0	0	0	0	0	0	57.2	0	0	11.6	0.3	3.6
2025	4	16	7	12	55	0	0	0	0	0	0	0	57.27	0	0	11.8	0.3	3.6
2025	4	16	7	22	55	0	0	0	0	0	0	0	57.34	0	0	12	0.3	3.6
2025	4	16	7	32	55	0	0	0	0	0	0	0	57.4	0	0	12.2	0.3	3.6
2025	4	16	7	42	55	0	0	0	0	0	0	0	57.42	0	0	12	0.3	3.6
2025	4	16	7	52	55	0	0	0	0	0	0	0	57.45	0	0	12	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	16	8	2	55	0	0	0	0	0	0	0	57.58	0	0	13	0.3	3.6
2025	4	16	8	12	55	0	0	0	0	0	0	0	57.69	0	0	13.4	0.3	3.6
2025	4	16	8	22	55	0	0	0	0	0	0	0	57.69	0	0	12.8	0.3	3.6
2025	4	16	8	32	55	0	0	0	0	0	0	0	57.79	0	0	13.6	0.3	3.6
2025	4	16	8	42	55	0	0	0	0	0	0	0	57.92	0	0	13.6	0.3	3.6
2025	4	16	8	52	55	0	0	0	0	0	0	0	58.03	0	0	13.4	0.3	3.6
2025	4	16	9	2	55	0	0	0	0	0	0	0	58.14	0	0	13.6	0.3	3.6
2025	4	16	9	12	55	0	0	0	0	0	0	0	58.24	0	0	13.4	0.3	3.6
2025	4	16	9	22	55	0	0	0	0	0	0	0	58.33	0	0	13.4	0.3	3.6
2025	4	16	9	32	55	0	0	0	0	0	0	0	58.46	0	0	13.4	0.3	3.6
2025	4	16	9	42	55	0	0	0	0	0	0	0	58.57	0	0	13.4	0.3	3.6
2025	4	16	9	52	55	0	0	0	0	0	0	0	58.66	0	0	13.4	0.3	3.6
2025	4	16	10	2	55	0	0	0	0	0	0	0	58.77	0	0	13.2	0.3	3.6
2025	4	16	10	12	55	0	0	0	0	0	0	0	58.87	0	0	13.2	0.3	3.6
2025	4	16	10	22	55	0	0	0	0	0	0	0	58.98	0	0	13.2	0.3	3.6
2025	4	16	10	32	55	0	0	0	0	0	0	0	59.11	0	0	13.6	0.3	3.6
2025	4	16	10	42	55	0	0	0	0	0	0	0	59.22	0	0	13.6	0.3	3.6
2025	4	16	10	52	55	0	0	0	0	0	0	0	59.32	0	0	13.6	0.3	3.6
2025	4	16	11	2	55	0	0	0	0	0	0	0	59.43	0	0	13.6	0.3	3.6
2025	4	16	11	12	55	0	0	0	0	0	0	0	59.5	0	0	13.6	0.3	3.6
2025	4	16	11	22	55	0	0	0	0	0	0	0	59.63	0	0	13.6	0.3	3.6
2025	4	16	11	32	55	0	0	0	0	0	0	0	59.76	0	0	13.6	0.3	3.6
2025	4	16	11	42	55	0	0	0	0	0	0	0	59.85	0	0	13.4	0.3	3.6
2025	4	16	11	52	55	0	0	0	0	0	0	0	59.95	0	0	13.4	0.3	3.6
2025	4	16	12	2	55	0	0	0	0	0	0	0	60.06	0	0	13.4	0.3	3.6
2025	4	16	12	12	55	0	0	0	0	0	0	0	60.15	0	0	13.4	0.3	3.6
2025	4	16	12	22	55	0	0	0	0	0	0	0	60.17	0	0	13.4	0.3	3.6
2025	4	16	12	32	55	0	0	0	0	0	0	0	60.26	0	0	13.2	0.3	3.6
2025	4	16	12	42	55	0	0	0	0	0	0	0	60.3	0	0	13.2	0.3	3.6
2025	4	16	12	52	55	0	0	0	0	0	0	0	60.46	0	0	13.2	0.3	3.6
2025	4	16	13	2	55	0	0	0	0	0	0	0	60.51	0	0	13.2	0.3	3.6
2025	4	16	13	12	55	0	0	0	0	0	0	0	60.6	0	0	13.2	0.3	3.6
2025	4	16	13	22	55	0	0	0	0	0	0	0	60.64	0	0	13.2	0.3	3.6
2025	4	16	13	32	55	0	0	0	0	0	0	0	60.66	0	0	13.2	0.3	3.6
2025	4	16	13	42	55	0	0	0	0	0	0	0	60.69	0	0	13.2	0.3	3.6
2025	4	16	13	52	55	0	0	0	0	0	0	0	60.71	0	0	13.2	0.3	3.6
2025	4	16	14	2	55	0	0	0	0	0	0	0	60.73	0	0	13.2	0.3	3.6
2025	4	16	14	12	55	0	0	0	0	0	0	0	60.75	0	0	13.2	0.3	3.6
2025	4	16	14	22	55	0	0	0	0	0	0	0	60.76	0	0	13.4	0.3	3.6
2025	4	16	14	32	55	0	0	0	0	0	0	0	60.76	0	0	13.4	0.3	3.6
2025	4	16	14	42	55	0	0	0	0	0	0	0	60.78	0	0	13.2	0.3	3.6
2025	4	16	14	52	55	0	0	0	0	0	0	0	60.8	0	0	13.2	0.3	3.6
2025	4	16	15	2	55	0	0	0	0	0	0	0	60.82	0	0	13.2	0.3	3.6
2025	4	16	15	12	55	0	0	0	0	0	0	0	60.84	0	0	13	0.3	3.6
2025	4	16	15	22	55	0	0	0	0	0	0	0	60.85	0	0	12.8	0.3	3.6
2025	4	16	15	32	55	0	0	0	0	0	0	0	60.75	0	0	11.8	0.3	3.6
2025	4	16	15	42	55	0	0	0	0	0	0	0	60.67	0	0	11.6	0.3	3.6
2025	4	16	15	52	55	0	0	0	0	0	0	0	60.64	0	0	11.4	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	16	16	2	55	0	0	0	0	0	0	0	60.57	0	0	11.2	0.3	3.6
2025	4	16	16	12	55	0	0	0	0	0	0	0	60.51	0	0	11.2	0.3	3.6
2025	4	16	16	22	55	0	0	0	0	0	0	0	60.46	0	0	11.4	0.3	3.6
2025	4	16	16	32	55	0	0	0	0	0	0	0	60.4	0	0	11.2	0.3	3.6
2025	4	16	16	42	55	0	0	0	0	0	0	0	60.33	0	0	11	0.3	3.6
2025	4	16	16	52	55	0	0	0	0	0	0	0	60.28	0	0	11.8	0.3	3.6
2025	4	16	17	2	55	0	0	0	0	0	0	0	60.24	0	0	11.8	0.3	3.6
2025	4	16	17	12	55	0	0	0	0	0	0	0	60.19	0	0	11.8	0.3	3.6
2025	4	16	17	22	55	0	0	0	0	0	0	0	60.12	0	0	11.8	0.3	3.6
2025	4	16	17	32	55	0	0	0	0	0	0	0	60.06	0	0	11.6	0.3	3.6
2025	4	16	17	42	55	0	0	0	0	0	0	0	60.01	0	0	11.6	0.3	3.6
2025	4	16	17	52	55	0	0	0	0	0	0	0	59.94	0	0	11.6	0.3	3.6
2025	4	16	18	2	55	0	0	0	0	0	0	0	59.88	0	0	11.6	0.3	3.6
2025	4	16	18	12	55	0	0	0	0	0	0	0	59.85	0	0	11.6	0.3	3.6
2025	4	16	18	22	55	0	0	0	0	0	0	0	59.77	0	0	11.6	0.3	3.6
2025	4	16	18	32	55	0	0	0	0	0	0	0	59.72	0	0	11.6	0.3	3.6
2025	4	16	18	42	55	0	0	0	0	0	0	0	59.67	0	0	11.6	0.3	3.6
2025	4	16	18	52	55	0	0	0	0	0	0	0	59.59	0	0	11.6	0.3	3.6
2025	4	16	19	2	55	0	0	0	0	0	0	0	59.52	0	0	11.6	0.3	3.6
2025	4	16	19	12	55	0	0	0	0	0	0	0	59.45	0	0	11.6	0.3	3.6
2025	4	16	19	22	55	0	0	0	0	0	0	0	59.38	0	0	11.6	0.3	3.6
2025	4	16	19	32	55	0	0	0	0	0	0	0	59.31	0	0	11.6	0.3	3.6
2025	4	16	19	42	55	0	0	0	0	0	0	0	59.23	0	0	11.6	0.3	3.6
2025	4	16	19	52	55	0	0	0	0	0	0	0	59.16	0	0	11.6	0.3	3.6
2025	4	16	20	2	55	0	0	0	0	0	0	0	59.09	0	0	11.6	0.3	3.6
2025	4	16	20	12	55	0	0	0	0	0	0	0	59.02	0	0	11.6	0.3	3.6
2025	4	16	20	22	55	0	0	0	0	0	0	0	58.95	0	0	11.6	0.3	3.6
2025	4	16	20	32	55	0	0	0	0	0	0	0	58.87	0	0	11.6	0.3	3.6
2025	4	16	20	42	55	0	0	0	0	0	0	0	58.8	0	0	11.6	0.3	3.6
2025	4	16	20	52	55	0	0	0	0	0	0	0	58.75	0	0	11.6	0.3	3.6
2025	4	16	21	2	55	0	0	0	0	0	0	0	58.68	0	0	11.6	0.3	3.6
2025	4	16	21	12	55	0	0	0	0	0	0	0	58.6	0	0	11.6	0.3	3.6
2025	4	16	21	22	55	0	0	0	0	0	0	0	58.55	0	0	11.6	0.3	3.6
2025	4	16	21	32	55	0	0	0	0	0	0	0	58.48	0	0	11.6	0.3	3.6
2025	4	16	21	42	55	0	0	0	0	0	0	0	58.41	0	0	11.6	0.3	3.6
2025	4	16	21	52	55	0	0	0	0	0	0	0	58.33	0	0	11.6	0.3	3.6
2025	4	16	22	2	55	0	0	0	0	0	0	0	58.28	0	0	11.6	0.3	3.6
2025	4	16	22	12	55	0	0	0	0	0	0	0	58.21	0	0	11.6	0.3	3.6
2025	4	16	22	22	55	0	0	0	0	0	0	0	58.14	0	0	11.6	0.3	3.6
2025	4	16	22	32	55	0	0	0	0	0	0	0	58.08	0	0	11.6	0.3	3.6
2025	4	16	22	42	55	0	0	0	0	0	0	0	58.03	0	0	11.6	0.3	3.6
2025	4	16	22	52	55	0	0	0	0	0	0	0	57.97	0	0	11.6	0.3	3.6
2025	4	16	23	2	55	0	0	0	0	0	0	0	57.92	0	0	11.6	0.3	3.6
2025	4	16	23	12	55	0	0	0	0	0	0	0	57.88	0	0	11.6	0.3	3.6
2025	4	16	23	22	55	0	0	0	0	0	0	0	57.85	0	0	11.6	0.3	3.6
2025	4	16	23	32	55	0	0	0	0	0	0	0	57.81	0	0	11.6	0.3	3.6
2025	4	16	23	42	55	0	0	0	0	0	0	0	57.78	0	0	11.6	0.3	3.6
2025	4	16	23	52	55	0	0	0	0	0	0	0	57.74	0	0	11.6	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	17	0	2	55	0	0	0	0	0	0	0	57.72	0	0	11.6	0.3	3.6
2025	4	17	0	12	55	0	0	0	0	0	0	0	57.7	0	0	11.6	0.3	3.6
2025	4	17	0	22	55	0	0	0	0	0	0	0	57.69	0	0	11.6	0.3	3.6
2025	4	17	0	32	55	0	0	0	0	0	0	0	57.69	0	0	11.6	0.3	3.6
2025	4	17	0	42	55	0	0	0	0	0	0	0	57.69	0	0	11.6	0.3	3.6
2025	4	17	0	52	55	0	0	0	0	0	0	0	57.69	0	0	11.4	0.3	3.6
2025	4	17	1	2	55	0	0	0	0	0	0	0	57.69	0	0	11.4	0.3	3.6
2025	4	17	1	12	55	0	0	0	0	0	0	0	57.69	0	0	11.4	0.3	3.6
2025	4	17	1	22	55	0	0	0	0	0	0	0	57.7	0	0	11.4	0.3	3.6
2025	4	17	1	32	55	0	0	0	0	0	0	0	57.7	0	0	11.4	0.3	3.6
2025	4	17	1	42	55	0	0	0	0	0	0	0	57.72	0	0	11.4	0.3	3.6
2025	4	17	1	52	55	0	0	0	0	0	0	0	57.72	0	0	11.4	0.3	3.6
2025	4	17	2	2	55	0	0	0	0	0	0	0	57.74	0	0	11.4	0.3	3.6
2025	4	17	2	12	55	0	0	0	0	0	0	0	57.72	0	0	11.4	0.3	3.6
2025	4	17	2	22	55	0	0	0	0	0	0	0	57.72	0	0	11.4	0.3	3.6
2025	4	17	2	32	55	0	0	0	0	0	0	0	57.72	0	0	11.4	0.3	3.6
2025	4	17	2	42	55	0	0	0	0	0	0	0	57.74	0	0	11.4	0.3	3.6
2025	4	17	2	52	55	0	0	0	0	0	0	0	57.72	0	0	11.4	0.3	3.6
2025	4	17	3	2	55	0	0	0	0	0	0	0	57.74	0	0	11.4	0.3	3.6
2025	4	17	3	12	55	0	0	0	0	0	0	0	57.74	0	0	11.4	0.3	3.6
2025	4	17	3	22	55	0	0	0	0	0	0	0	57.74	0	0	11.4	0.3	3.6
2025	4	17	3	32	55	0	0	0	0	0	0	0	57.76	0	0	11.4	0.3	3.6
2025	4	17	3	42	55	0	0	0	0	0	0	0	57.76	0	0	11.4	0.3	3.6
2025	4	17	3	52	55	0	0	0	0	0	0	0	57.76	0	0	11.4	0.3	3.6
2025	4	17	4	2	55	0	0	0	0	0	0	0	57.76	0	0	11.4	0.3	3.6
2025	4	17	4	12	55	0	0	0	0	0	0	0	57.76	0	0	11.4	0.3	3.6
2025	4	17	4	22	55	0	0	0	0	0	0	0	57.76	0	0	11.4	0.3	3.6
2025	4	17	4	32	55	0	0	0	0	0	0	0	57.76	0	0	11.4	0.3	3.6
2025	4	17	4	42	55	0	0	0	0	0	0	0	57.74	0	0	11.4	0.3	3.6
2025	4	17	4	52	55	0	0	0	0	0	0	0	57.76	0	0	11.4	0.3	3.6
2025	4	17	5	2	55	0	0	0	0	0	0	0	57.76	0	0	11.4	0.3	3.6
2025	4	17	5	12	55	0	0	0	0	0	0	0	57.76	0	0	11.4	0.3	3.6
2025	4	17	5	22	55	0	0	0	0	0	0	0	57.78	0	0	11.4	0.3	3.6
2025	4	17	5	32	55	0	0	0	0	0	0	0	57.78	0	0	11.4	0.3	3.6
2025	4	17	5	42	55	0	0	0	0	0	0	0	57.78	0	0	11.4	0.3	3.6
2025	4	17	5	52	55	0	0	0	0	0	0	0	57.79	0	0	11.4	0.3	3.6
2025	4	17	6	2	55	0	0	0	0	0	0	0	57.79	0	0	11.4	0.3	3.6
2025	4	17	6	12	55	0	0	0	0	0	0	0	57.81	0	0	11.4	0.3	3.6
2025	4	17	6	22	55	0	0	0	0	0	0	0	57.81	0	0	11.6	0.3	3.6
2025	4	17	6	32	55	0	0	0	0	0	0	0	57.83	0	0	11.4	0.3	3.6
2025	4	17	6	42	55	0	0	0	0	0	0	0	57.85	0	0	11.6	0.3	3.6
2025	4	17	6	52	55	0	0	0	0	0	0	0	57.87	0	0	11.6	0.3	3.6
2025	4	17	7	2	55	0	0	0	0	0	0	0	57.9	0	0	12	0.3	3.6
2025	4	17	7	12	55	0	0	0	0	0	0	0	57.96	0	0	12.4	0.3	3.6
2025	4	17	7	22	55	0	0	0	0	0	0	0	57.99	0	0	12.4	0.3	3.6
2025	4	17	7	32	55	0	0	0	0	0	0	0	58.03	0	0	12.2	0.3	3.6
2025	4	17	7	42	55	0	0	0	0	0	0	0	58.12	0	0	13	0.3	3.6
2025	4	17	7	52	55	0	0	0	0	0	0	0	58.17	0	0	13	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	17	8	2	55	0	0	0	0	0	0	0	58.19	0	0	12.6	0.3	3.6
2025	4	17	8	12	55	0	0	0	0	0	0	0	58.28	0	0	13.4	0.3	3.6
2025	4	17	8	22	55	0	0	0	0	0	0	0	58.41	0	0	13.6	0.3	3.6
2025	4	17	8	32	55	0	0	0	0	0	0	0	58.44	0	0	13.4	0.3	3.6
2025	4	17	8	42	55	0	0	0	0	0	0	0	58.55	0	0	13.8	0.3	3.6
2025	4	17	8	52	55	0	0	0	0	0	0	0	58.64	0	0	13.8	0.3	3.6
2025	4	17	9	2	55	0	0	0	0	0	0	0	58.75	0	0	13.8	0.3	3.6
2025	4	17	9	12	55	0	0	0	0	0	0	0	58.82	0	0	13.8	0.3	3.6
2025	4	17	9	22	55	0	0	0	0	0	0	0	58.93	0	0	13.6	0.3	3.6
2025	4	17	9	32	55	0	0	0	0	0	0	0	59.02	0	0	13.6	0.3	3.6
2025	4	17	9	42	55	0	0	0	0	0	0	0	59.11	0	0	13.4	0.3	3.6
2025	4	17	9	52	55	0	0	0	0	0	0	0	59.2	0	0	13.4	0.3	3.6
2025	4	17	10	2	55	0	0	0	0	0	0	0	59.29	0	0	13.4	0.3	3.6
2025	4	17	10	12	55	0	0	0	0	0	0	0	59.38	0	0	13.4	0.3	3.6
2025	4	17	10	22	55	0	0	0	0	0	0	0	59.49	0	0	13.4	0.3	3.6
2025	4	17	10	32	55	0	0	0	0	0	0	0	59.59	0	0	13.4	0.3	3.6
2025	4	17	10	42	55	0	0	0	0	0	0	0	59.72	0	0	13.4	0.3	3.6
2025	4	17	10	52	55	0	0	0	0	0	0	0	59.79	0	0	13.4	0.3	3.6
2025	4	17	11	2	55	0	0	0	0	0	0	0	59.92	0	0	13.4	0.3	3.6
2025	4	17	11	12	55	0	0	0	0	0	0	0	60.03	0	0	13.4	0.3	3.6
2025	4	17	11	22	55	0	0	0	0	0	0	0	60.12	0	0	13.4	0.3	3.6
2025	4	17	11	32	55	0	0	0	0	0	0	0	60.22	0	0	13.2	0.3	3.6
2025	4	17	11	42	55	0	0	0	0	0	0	0	60.31	0	0	13.2	0.3	3.6
2025	4	17	11	52	55	0	0	0	0	0	0	0	60.39	0	0	13.2	0.3	3.6
2025	4	17	12	2	55	0	0	0	0	0	0	0	60.49	0	0	13.2	0.3	3.6
2025	4	17	12	12	55	0	0	0	0	0	0	0	60.58	0	0	13.2	0.3	3.6
2025	4	17	12	22	55	0	0	0	0	0	0	0	60.66	0	0	13.6	0.3	3.6
2025	4	17	12	32	55	0	0	0	0	0	0	0	60.75	0	0	13.4	0.3	3.6
2025	4	17	12	42	55	0	0	0	0	0	0	0	60.84	0	0	13.6	0.3	3.6
2025	4	17	12	52	55	0	0	0	0	0	0	0	60.91	0	0	13.6	0.3	3.6
2025	4	17	13	2	55	0	0	0	0	0	0	0	60.91	0	0	13.4	0.3	3.6
2025	4	17	13	12	55	0	0	0	0	0	0	0	60.75	0	0	12.6	0.3	3.6
2025	4	17	13	22	55	0	0	0	0	0	0	0	60.69	0	0	12.8	0.3	3.6
2025	4	17	13	32	55	0	0	0	0	0	0	0	60.66	0	0	12.4	0.3	3.6
2025	4	17	13	42	55	0	0	0	0	0	0	0	60.6	0	0	12.2	0.3	3.6
2025	4	17	13	52	55	0	0	0	0	0	0	0	60.53	0	0	11.8	0.3	3.6
2025	4	17	14	2	55	0	0	0	0	0	0	0	60.49	0	0	11.8	0.3	3.6
2025	4	17	14	12	55	0	0	0	0	0	0	0	60.48	0	0	12	0.3	3.6
2025	4	17	14	22	55	0	0	0	0	0	0	0	60.46	0	0	12.2	0.3	3.6
2025	4	17	14	32	55	0	0	0	0	0	0	0	60.48	0	0	13	0.3	3.6
2025	4	17	14	42	55	0	0	0	0	0	0	0	60.6	0	0	13.6	0.3	3.6
2025	4	17	14	52	55	0	0	0	0	0	0	0	60.69	0	0	13.8	0.3	3.6
2025	4	17	15	2	55	0	0	0	0	0	0	0	60.75	0	0	13.8	0.3	3.6
2025	4	17	15	12	55	0	0	0	0	0	0	0	60.76	0	0	13.8	0.3	3.6
2025	4	17	15	22	55	0	0	0	0	0	0	0	60.8	0	0	13.6	0.3	3.6
2025	4	17	15	32	55	0	0	0	0	0	0	0	60.78	0	0	13.6	0.3	3.6
2025	4	17	15	42	55	0	0	0	0	0	0	0	60.76	0	0	13.4	0.3	3.6
2025	4	17	15	52	55	0	0	0	0	0	0	0	60.75	0	0	13.4	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	17	16	2	55	0	0	0	0	0	0	0	60.73	0	0	13.4	0.3	3.6
2025	4	17	16	12	55	0	0	0	0	0	0	0	60.67	0	0	13.4	0.3	3.6
2025	4	17	16	22	55	0	0	0	0	0	0	0	60.64	0	0	12.8	0.3	3.6
2025	4	17	16	32	55	0	0	0	0	0	0	0	60.58	0	0	12.8	0.3	3.6
2025	4	17	16	42	55	0	0	0	0	0	0	0	60.53	0	0	12.4	0.3	3.6
2025	4	17	16	52	55	0	0	0	0	0	0	0	60.46	0	0	12.2	0.3	3.6
2025	4	17	17	2	55	0	0	0	0	0	0	0	60.39	0	0	12.2	0.3	3.6
2025	4	17	17	12	55	0	0	0	0	0	0	0	60.31	0	0	12	0.3	3.6
2025	4	17	17	22	55	0	0	0	0	0	0	0	60.24	0	0	11.8	0.3	3.6
2025	4	17	17	32	55	0	0	0	0	0	0	0	60.15	0	0	11.8	0.3	3.6
2025	4	17	17	42	55	0	0	0	0	0	0	0	60.08	0	0	11.8	0.3	3.6
2025	4	17	17	52	55	0	0	0	0	0	0	0	59.99	0	0	11.8	0.3	3.6
2025	4	17	18	2	55	0	0	0	0	0	0	0	59.92	0	0	11.8	0.3	3.6
2025	4	17	18	12	55	0	0	0	0	0	0	0	59.85	0	0	11.6	0.3	3.6
2025	4	17	18	22	55	0	0	0	0	0	0	0	59.76	0	0	11.6	0.3	3.6
2025	4	17	18	32	55	0	0	0	0	0	0	0	59.68	0	0	11.6	0.3	3.6
2025	4	17	18	42	55	0	0	0	0	0	0	0	59.59	0	0	11.6	0.3	3.6
2025	4	17	18	52	55	0	0	0	0	0	0	0	59.5	0	0	11.6	0.3	3.6
2025	4	17	19	2	55	0	0	0	0	0	0	0	59.43	0	0	11.6	0.3	3.6
2025	4	17	19	12	55	0	0	0	0	0	0	0	59.34	0	0	11.6	0.3	3.6
2025	4	17	19	22	55	0	0	0	0	0	0	0	59.25	0	0	11.6	0.3	3.6
2025	4	17	19	32	55	0	0	0	0	0	0	0	59.16	0	0	11.6	0.3	3.6
2025	4	17	19	42	55	0	0	0	0	0	0	0	59.05	0	0	11.6	0.3	3.6
2025	4	17	19	52	55	0	0	0	0	0	0	0	58.96	0	0	11.6	0.3	3.6
2025	4	17	20	2	55	0	0	0	0	0	0	0	58.86	0	0	11.6	0.3	3.6
2025	4	17	20	12	55	0	0	0	0	0	0	0	58.77	0	0	11.6	0.3	3.6
2025	4	17	20	22	55	0	0	0	0	0	0	0	58.68	0	0	11.6	0.3	3.6
2025	4	17	20	32	55	0	0	0	0	0	0	0	58.57	0	0	11.6	0.3	3.6
2025	4	17	20	42	55	0	0	0	0	0	0	0	58.48	0	0	11.6	0.3	3.6
2025	4	17	20	52	55	0	0	0	0	0	0	0	58.39	0	0	11.6	0.3	3.6
2025	4	17	21	2	55	0	0	0	0	0	0	0	58.32	0	0	11.6	0.3	3.6
2025	4	17	21	12	55	0	0	0	0	0	0	0	58.21	0	0	11.6	0.3	3.6
2025	4	17	21	22	55	0	0	0	0	0	0	0	58.14	0	0	11.6	0.3	3.6
2025	4	17	21	32	55	0	0	0	0	0	0	0	58.06	0	0	11.6	0.3	3.6
2025	4	17	21	42	55	0	0	0	0	0	0	0	57.97	0	0	11.6	0.3	3.6
2025	4	17	21	52	55	0	0	0	0	0	0	0	57.9	0	0	11.6	0.3	3.6
2025	4	17	22	2	55	0	0	0	0	0	0	0	57.83	0	0	11.6	0.3	3.6
2025	4	17	22	12	55	0	0	0	0	0	0	0	57.76	0	0	11.6	0.3	3.6
2025	4	17	22	22	55	0	0	0	0	0	0	0	57.7	0	0	11.6	0.3	3.6
2025	4	17	22	32	55	0	0	0	0	0	0	0	57.63	0	0	11.6	0.3	3.6
2025	4	17	22	42	55	0	0	0	0	0	0	0	57.58	0	0	11.6	0.3	3.6
2025	4	17	22	52	55	0	0	0	0	0	0	0	57.52	0	0	11.6	0.3	3.6
2025	4	17	23	2	55	0	0	0	0	0	0	0	57.47	0	0	11.6	0.3	3.6
2025	4	17	23	12	55	0	0	0	0	0	0	0	57.45	0	0	11.6	0.3	3.6
2025	4	17	23	22	55	0	0	0	0	0	0	0	57.4	0	0	11.6	0.3	3.6
2025	4	17	23	32	55	0	0	0	0	0	0	0	57.38	0	0	11.6	0.3	3.6
2025	4	17	23	42	55	0	0	0	0	0	0	0	57.34	0	0	11.6	0.3	3.6
2025	4	17	23	52	55	0	0	0	0	0	0	0	57.31	0	0	11.6	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	18	0	2	55	0	0	0	0	0	0	0	57.27	0	0	11.6	0.3	3.6
2025	4	18	0	12	55	0	0	0	0	0	0	0	57.24	0	0	11.6	0.3	3.6
2025	4	18	0	22	55	0	0	0	0	0	0	0	57.22	0	0	11.6	0.3	3.6
2025	4	18	0	32	55	0	0	0	0	0	0	0	57.18	0	0	11.6	0.3	3.6
2025	4	18	0	42	55	0	0	0	0	0	0	0	57.15	0	0	11.6	0.3	3.6
2025	4	18	0	52	55	0	0	0	0	0	0	0	57.11	0	0	11.6	0.3	3.6
2025	4	18	1	2	55	0	0	0	0	0	0	0	57.07	0	0	11.6	0.3	3.6
2025	4	18	1	12	55	0	0	0	0	0	0	0	57.04	0	0	11.6	0.3	3.6
2025	4	18	1	22	55	0	0	0	0	0	0	0	57	0	0	11.4	0.3	3.6
2025	4	18	1	32	55	0	0	0	0	0	0	0	56.97	0	0	11.4	0.3	3.6
2025	4	18	1	42	55	0	0	0	0	0	0	0	56.95	0	0	11.4	0.3	3.6
2025	4	18	1	52	55	0	0	0	0	0	0	0	56.91	0	0	11.4	0.3	3.6
2025	4	18	2	2	55	0	0	0	0	0	0	0	56.89	0	0	11.4	0.3	3.6
2025	4	18	2	12	55	0	0	0	0	0	0	0	56.86	0	0	11.4	0.3	3.6
2025	4	18	2	22	55	0	0	0	0	0	0	0	56.82	0	0	11.4	0.3	3.6
2025	4	18	2	32	55	0	0	0	0	0	0	0	56.82	0	0	11.4	0.3	3.6
2025	4	18	2	42	55	0	0	0	0	0	0	0	56.8	0	0	11.4	0.3	3.6
2025	4	18	2	52	55	0	0	0	0	0	0	0	56.77	0	0	11.4	0.3	3.6
2025	4	18	3	2	55	0	0	0	0	0	0	0	56.75	0	0	11.4	0.3	3.6
2025	4	18	3	12	55	0	0	0	0	0	0	0	56.73	0	0	11.4	0.3	3.6
2025	4	18	3	22	55	0	0	0	0	0	0	0	56.73	0	0	11.4	0.3	3.6
2025	4	18	3	32	55	0	0	0	0	0	0	0	56.7	0	0	11.4	0.3	3.6
2025	4	18	3	42	55	0	0	0	0	0	0	0	56.68	0	0	11.4	0.3	3.6
2025	4	18	3	52	55	0	0	0	0	0	0	0	56.66	0	0	11.4	0.3	3.6
2025	4	18	4	2	55	0	0	0	0	0	0	0	56.64	0	0	11.4	0.3	3.6
2025	4	18	4	12	55	0	0	0	0	0	0	0	56.62	0	0	11.4	0.3	3.6
2025	4	18	4	22	55	0	0	0	0	0	0	0	56.61	0	0	11.4	0.3	3.6
2025	4	18	4	32	55	0	0	0	0	0	0	0	56.59	0	0	11.4	0.3	3.6
2025	4	18	4	42	55	0	0	0	0	0	0	0	56.57	0	0	11.4	0.3	3.6
2025	4	18	4	52	55	0	0	0	0	0	0	0	56.55	0	0	11.4	0.3	3.6
2025	4	18	5	2	55	0	0	0	0	0	0	0	56.53	0	0	11.4	0.3	3.6
2025	4	18	5	12	55	0	0	0	0	0	0	0	56.53	0	0	11.4	0.3	3.6
2025	4	18	5	22	55	0	0	0	0	0	0	0	56.52	0	0	11.4	0.3	3.6
2025	4	18	5	32	55	0	0	0	0	0	0	0	56.5	0	0	11.4	0.3	3.6
2025	4	18	5	42	55	0	0	0	0	0	0	0	56.48	0	0	11.4	0.3	3.6
2025	4	18	5	52	55	0	0	0	0	0	0	0	56.5	0	0	11.4	0.3	3.6
2025	4	18	6	2	55	0	0	0	0	0	0	0	56.5	0	0	11.4	0.3	3.6
2025	4	18	6	12	55	0	0	0	0	0	0	0	56.48	0	0	11.6	0.3	3.6
2025	4	18	6	22	55	0	0	0	0	0	0	0	56.5	0	0	11.8	0.3	3.6
2025	4	18	6	32	55	0	0	0	0	0	0	0	56.5	0	0	12	0.3	3.6
2025	4	18	6	42	55	0	0	0	0	0	0	0	56.53	0	0	12.2	0.3	3.6
2025	4	18	6	52	55	0	0	0	0	0	0	0	56.55	0	0	12.4	0.3	3.6
2025	4	18	7	2	55	0	0	0	0	0	0	0	56.55	0	0	12.6	0.3	3.6
2025	4	18	7	12	55	0	0	0	0	0	0	0	56.59	0	0	12.6	0.3	3.6
2025	4	18	7	22	55	0	0	0	0	0	0	0	56.61	0	0	13	0.3	3.6
2025	4	18	7	32	55	0	0	0	0	0	0	0	56.66	0	0	13.2	0.3	3.6
2025	4	18	7	42	55	0	0	0	0	0	0	0	56.68	0	0	13.4	0.3	3.6
2025	4	18	7	52	55	0	0	0	0	0	0	0	56.73	0	0	13.6	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	18	8	2	55	0	0	0	0	0	0	0	56.79	0	0	13.8	0.3	3.6
2025	4	18	8	12	55	0	0	0	0	0	0	0	56.8	0	0	14	0.3	3.6
2025	4	18	8	22	55	0	0	0	0	0	0	0	56.84	0	0	13.6	0.3	3.6
2025	4	18	8	32	55	0	0	0	0	0	0	0	56.89	0	0	14	0.3	3.6
2025	4	18	8	42	55	0	0	0	0	0	0	0	56.93	0	0	14	0.3	3.6
2025	4	18	8	52	55	0	0	0	0	0	0	0	57	0	0	13.8	0.3	3.6
2025	4	18	9	2	55	0	0	0	0	0	0	0	57.07	0	0	13.8	0.3	3.6
2025	4	18	9	12	55	0	0	0	0	0	0	0	57.15	0	0	13.8	0.3	3.6
2025	4	18	9	22	55	0	0	0	0	0	0	0	57.22	0	0	13.8	0.3	3.6
2025	4	18	9	32	55	0	0	0	0	0	0	0	57.29	0	0	13.8	0.3	3.6
2025	4	18	9	42	55	0	0	0	0	0	0	0	57.36	0	0	13.8	0.3	3.6
2025	4	18	9	52	55	0	0	0	0	0	0	0	57.45	0	0	13.6	0.3	3.6
2025	4	18	10	2	55	0	0	0	0	0	0	0	57.51	0	0	13.8	0.3	3.6
2025	4	18	10	12	55	0	0	0	0	0	0	0	57.6	0	0	13.8	0.3	3.6
2025	4	18	10	22	55	0	0	0	0	0	0	0	57.69	0	0	13.8	0.3	3.6
2025	4	18	10	32	55	0	0	0	0	0	0	0	57.76	0	0	13.8	0.3	3.6
2025	4	18	10	42	55	0	0	0	0	0	0	0	57.81	0	0	13.8	0.3	3.6
2025	4	18	10	52	55	0	0	0	0	0	0	0	57.87	0	0	13.8	0.3	3.6
2025	4	18	11	2	55	0	0	0	0	0	0	0	57.96	0	0	13.8	0.3	3.6
2025	4	18	11	12	55	0	0	0	0	0	0	0	58.01	0	0	13.8	0.3	3.6
2025	4	18	11	22	55	0	0	0	0	0	0	0	58.1	0	0	13.8	0.3	3.6
2025	4	18	11	32	55	0	0	0	0	0	0	0	58.17	0	0	13.8	0.3	3.6
2025	4	18	11	42	55	0	0	0	0	0	0	0	58.23	0	0	13.8	0.3	3.6
2025	4	18	11	52	55	0	0	0	0	0	0	0	58.28	0	0	13.8	0.3	3.6
2025	4	18	12	2	55	0	0	0	0	0	0	0	58.33	0	0	13.8	0.3	3.6
2025	4	18	12	12	55	0	0	0	0	0	0	0	58.39	0	0	13.8	0.3	3.6
2025	4	18	12	22	55	0	0	0	0	0	0	0	58.42	0	0	13.8	0.3	3.6
2025	4	18	12	32	55	0	0	0	0	0	0	0	58.5	0	0	13.8	0.3	3.6
2025	4	18	12	42	55	0	0	0	0	0	0	0	58.51	0	0	13.8	0.3	3.6
2025	4	18	12	52	55	0	0	0	0	0	0	0	58.55	0	0	13.8	0.3	3.6
2025	4	18	13	2	55	0	0	0	0	0	0	0	58.59	0	0	13.8	0.3	3.6
2025	4	18	13	12	55	0	0	0	0	0	0	0	58.62	0	0	13.8	0.3	3.6
2025	4	18	13	22	55	0	0	0	0	0	0	0	58.64	0	0	13.6	0.3	3.6
2025	4	18	13	32	55	0	0	0	0	0	0	0	58.66	0	0	13.8	0.3	3.6
2025	4	18	13	42	55	0	0	0	0	0	0	0	58.68	0	0	13.8	0.3	3.6
2025	4	18	13	52	55	0	0	0	0	0	0	0	58.68	0	0	13.8	0.3	3.6
2025	4	18	14	2	55	0	0	0	0	0	0	0	58.68	0	0	13.8	0.3	3.6
2025	4	18	14	12	55	0	0	0	0	0	0	0	58.69	0	0	13.8	0.3	3.6
2025	4	18	14	22	55	0	0	0	0	0	0	0	58.69	0	0	13.8	0.3	3.6
2025	4	18	14	32	55	0	0	0	0	0	0	0	58.69	0	0	13.8	0.3	3.6
2025	4	18	14	42	55	0	0	0	0	0	0	0	58.66	0	0	13.8	0.3	3.6
2025	4	18	14	52	55	0	0	0	0	0	0	0	58.64	0	0	13.8	0.3	3.6
2025	4	18	15	2	55	0	0	0	0	0	0	0	58.64	0	0	13.8	0.3	3.6
2025	4	18	15	12	55	0	0	0	0	0	0	0	58.6	0	0	13.8	0.3	3.6
2025	4	18	15	22	55	0	0	0	0	0	0	0	58.57	0	0	13.8	0.3	3.6
2025	4	18	15	32	55	0	0	0	0	0	0	0	58.53	0	0	13.8	0.3	3.6
2025	4	18	15	42	55	0	0	0	0	0	0	0	58.48	0	0	13.8	0.3	3.6
2025	4	18	15	52	55	0	0	0	0	0	0	0	58.46	0	0	13.8	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	18	16	2	55	0	0	0	0	0	0	0	58.41	0	0	13	0.3	3.6
2025	4	18	16	12	55	0	0	0	0	0	0	0	58.35	0	0	12.6	0.3	3.6
2025	4	18	16	22	55	0	0	0	0	0	0	0	58.28	0	0	12.4	0.3	3.6
2025	4	18	16	32	55	0	0	0	0	0	0	0	58.21	0	0	12.4	0.3	3.6
2025	4	18	16	42	55	0	0	0	0	0	0	0	58.14	0	0	12.2	0.3	3.6
2025	4	18	16	52	55	0	0	0	0	0	0	0	58.06	0	0	12	0.3	3.6
2025	4	18	17	2	55	0	0	0	0	0	0	0	57.97	0	0	11.8	0.3	3.6
2025	4	18	17	12	55	0	0	0	0	0	0	0	57.9	0	0	11.8	0.3	3.6
2025	4	18	17	22	55	0	0	0	0	0	0	0	57.83	0	0	11.8	0.3	3.6
2025	4	18	17	32	55	0	0	0	0	0	0	0	57.74	0	0	11.8	0.3	3.6
2025	4	18	17	42	55	0	0	0	0	0	0	0	57.63	0	0	11.8	0.3	3.6
2025	4	18	17	52	55	0	0	0	0	0	0	0	57.56	0	0	11.6	0.3	3.6
2025	4	18	18	2	55	0	0	0	0	0	0	0	57.45	0	0	11.6	0.3	3.6
2025	4	18	18	12	55	0	0	0	0	0	0	0	57.38	0	0	11.6	0.3	3.6
2025	4	18	18	22	55	0	0	0	0	0	0	0	57.27	0	0	11.6	0.3	3.6
2025	4	18	18	32	55	0	0	0	0	0	0	0	57.18	0	0	11.6	0.3	3.6
2025	4	18	18	42	55	0	0	0	0	0	0	0	57.07	0	0	11.6	0.3	3.6
2025	4	18	18	52	55	0	0	0	0	0	0	0	56.97	0	0	11.6	0.3	3.6
2025	4	18	19	2	55	0	0	0	0	0	0	0	56.88	0	0	11.6	0.3	3.6
2025	4	18	19	12	55	0	0	0	0	0	0	0	56.77	0	0	11.6	0.3	3.6
2025	4	18	19	22	55	0	0	0	0	0	0	0	56.66	0	0	11.6	0.3	3.6
2025	4	18	19	32	55	0	0	0	0	0	0	0	56.55	0	0	11.6	0.3	3.6
2025	4	18	19	42	55	0	0	0	0	0	0	0	56.44	0	0	11.6	0.3	3.6
2025	4	18	19	52	55	0	0	0	0	0	0	0	56.34	0	0	11.6	0.3	3.6
2025	4	18	20	2	55	0	0	0	0	0	0	0	56.25	0	0	11.6	0.3	3.6
2025	4	18	20	12	55	0	0	0	0	0	0	0	56.14	0	0	11.6	0.3	3.6
2025	4	18	20	22	55	0	0	0	0	0	0	0	56.03	0	0	11.6	0.3	3.6
2025	4	18	20	32	55	0	0	0	0	0	0	0	55.94	0	0	11.6	0.3	3.6
2025	4	18	20	42	55	0	0	0	0	0	0	0	55.83	0	0	11.6	0.3	3.6
2025	4	18	20	52	55	0	0	0	0	0	0	0	55.72	0	0	11.6	0.3	3.6
2025	4	18	21	2	55	0	0	0	0	0	0	0	55.62	0	0	11.6	0.3	3.6
2025	4	18	21	12	55	0	0	0	0	0	0	0	55.53	0	0	11.6	0.3	3.6
2025	4	18	21	22	55	0	0	0	0	0	0	0	55.44	0	0	11.6	0.3	3.6
2025	4	18	21	32	55	0	0	0	0	0	0	0	55.35	0	0	11.6	0.3	3.6
2025	4	18	21	42	55	0	0	0	0	0	0	0	55.24	0	0	11.6	0.3	3.6
2025	4	18	21	52	55	0	0	0	0	0	0	0	55.17	0	0	11.6	0.3	3.6
2025	4	18	22	2	55	0	0	0	0	0	0	0	55.08	0	0	11.6	0.3	3.6
2025	4	18	22	12	55	0	0	0	0	0	0	0	55	0	0	11.6	0.3	3.6
2025	4	18	22	22	55	0	0	0	0	0	0	0	54.93	0	0	11.6	0.3	3.6
2025	4	18	22	32	55	0	0	0	0	0	0	0	54.88	0	0	11.6	0.3	3.6
2025	4	18	22	42	55	0	0	0	0	0	0	0	54.81	0	0	11.6	0.3	3.6
2025	4	18	22	52	55	0	0	0	0	0	0	0	54.75	0	0	11.6	0.3	3.6
2025	4	18	23	2	55	0	0	0	0	0	0	0	54.7	0	0	11.6	0.3	3.6
2025	4	18	23	12	55	0	0	0	0	0	0	0	54.64	0	0	11.6	0.3	3.6
2025	4	18	23	22	55	0	0	0	0	0	0	0	54.59	0	0	11.6	0.3	3.6
2025	4	18	23	32	55	0	0	0	0	0	0	0	54.54	0	0	11.6	0.3	3.6
2025	4	18	23	42	55	0	0	0	0	0	0	0	54.46	0	0	11.6	0.3	3.6
2025	4	18	23	52	55	0	0	0	0	0	0	0	54.43	0	0	11.6	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	19	0	2	55	0	0	0	0	0	0	0	54.39	0	0	11.6	0.3	3.6
2025	4	19	0	12	55	0	0	0	0	0	0	0	54.34	0	0	11.6	0.3	3.6
2025	4	19	0	22	55	0	0	0	0	0	0	0	54.3	0	0	11.6	0.3	3.6
2025	4	19	0	32	55	0	0	0	0	0	0	0	54.27	0	0	11.6	0.3	3.6
2025	4	19	0	42	55	0	0	0	0	0	0	0	54.25	0	0	11.4	0.3	3.6
2025	4	19	0	52	55	0	0	0	0	0	0	0	54.21	0	0	11.4	0.3	3.6
2025	4	19	1	2	55	0	0	0	0	0	0	0	54.18	0	0	11.4	0.3	3.6
2025	4	19	1	12	55	0	0	0	0	0	0	0	54.16	0	0	11.4	0.3	3.6
2025	4	19	1	22	55	0	0	0	0	0	0	0	54.14	0	0	11.4	0.3	3.6
2025	4	19	1	32	55	0	0	0	0	0	0	0	54.12	0	0	11.4	0.3	3.6
2025	4	19	1	42	55	0	0	0	0	0	0	0	54.09	0	0	11.4	0.3	3.6
2025	4	19	1	52	55	0	0	0	0	0	0	0	54.09	0	0	11.4	0.3	3.6
2025	4	19	2	2	55	0	0	0	0	0	0	0	54.09	0	0	11.4	0.3	3.6
2025	4	19	2	12	55	0	0	0	0	0	0	0	54.09	0	0	11.4	0.3	3.6
2025	4	19	2	22	55	0	0	0	0	0	0	0	54.07	0	0	11.4	0.3	3.6
2025	4	19	2	32	55	0	0	0	0	0	0	0	54.07	0	0	11.4	0.3	3.6
2025	4	19	2	42	55	0	0	0	0	0	0	0	54.07	0	0	11.4	0.3	3.6
2025	4	19	2	52	55	0	0	0	0	0	0	0	54.07	0	0	11.4	0.3	3.6
2025	4	19	3	2	55	0	0	0	0	0	0	0	54.05	0	0	11.4	0.3	3.6
2025	4	19	3	12	55	0	0	0	0	0	0	0	54.05	0	0	11.4	0.3	3.6
2025	4	19	3	22	55	0	0	0	0	0	0	0	54.05	0	0	11.4	0.3	3.6
2025	4	19	3	32	55	0	0	0	0	0	0	0	54.05	0	0	11.4	0.3	3.6
2025	4	19	3	42	55	0	0	0	0	0	0	0	54.05	0	0	11.4	0.3	3.6
2025	4	19	3	52	55	0	0	0	0	0	0	0	54.05	0	0	11.4	0.3	3.6
2025	4	19	4	2	55	0	0	0	0	0	0	0	54.03	0	0	11.4	0.3	3.6
2025	4	19	4	12	55	0	0	0	0	0	0	0	54.03	0	0	11.4	0.3	3.6
2025	4	19	4	22	55	0	0	0	0	0	0	0	54.03	0	0	11.4	0.3	3.6
2025	4	19	4	32	55	0	0	0	0	0	0	0	54.03	0	0	11.4	0.3	3.6
2025	4	19	4	42	55	0	0	0	0	0	0	0	54.03	0	0	11.4	0.3	3.6
2025	4	19	4	52	55	0	0	0	0	0	0	0	54.01	0	0	11.4	0.3	3.6
2025	4	19	5	2	55	0	0	0	0	0	0	0	54	0	0	11.4	0.3	3.6
2025	4	19	5	12	55	0	0	0	0	0	0	0	54	0	0	11.4	0.3	3.6
2025	4	19	5	22	55	0	0	0	0	0	0	0	53.98	0	0	11.4	0.3	3.6
2025	4	19	5	32	55	0	0	0	0	0	0	0	53.98	0	0	11.4	0.3	3.6
2025	4	19	5	42	55	0	0	0	0	0	0	0	53.96	0	0	11.4	0.3	3.6
2025	4	19	5	52	55	0	0	0	0	0	0	0	53.96	0	0	11.4	0.3	3.6
2025	4	19	6	2	55	0	0	0	0	0	0	0	53.94	0	0	11.4	0.3	3.6
2025	4	19	6	12	55	0	0	0	0	0	0	0	53.92	0	0	11.6	0.3	3.6
2025	4	19	6	22	55	0	0	0	0	0	0	0	53.92	0	0	11.8	0.3	3.6
2025	4	19	6	32	55	0	0	0	0	0	0	0	53.92	0	0	12	0.3	3.6
2025	4	19	6	42	55	0	0	0	0	0	0	0	53.96	0	0	12.2	0.3	3.6
2025	4	19	6	52	55	0	0	0	0	0	0	0	53.98	0	0	12.4	0.3	3.6
2025	4	19	7	2	55	0	0	0	0	0	0	0	54.01	0	0	12.6	0.3	3.6
2025	4	19	7	12	55	0	0	0	0	0	0	0	54.05	0	0	12.6	0.3	3.6
2025	4	19	7	22	55	0	0	0	0	0	0	0	54.09	0	0	12.6	0.3	3.6
2025	4	19	7	32	55	0	0	0	0	0	0	0	54.14	0	0	12.8	0.3	3.6
2025	4	19	7	42	55	0	0	0	0	0	0	0	54.21	0	0	12.8	0.3	3.6
2025	4	19	7	52	55	0	0	0	0	0	0	0	54.27	0	0	13.2	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	19	8	2	55	0	0	0	0	0	0	0	54.32	0	0	13.4	0.3	3.6
2025	4	19	8	12	55	0	0	0	0	0	0	0	54.39	0	0	13.8	0.3	3.6
2025	4	19	8	22	55	0	0	0	0	0	0	0	54.46	0	0	14	0.3	3.6
2025	4	19	8	32	55	0	0	0	0	0	0	0	54.54	0	0	13.8	0.3	3.6
2025	4	19	8	42	55	0	0	0	0	0	0	0	54.61	0	0	13.8	0.3	3.6
2025	4	19	8	52	55	0	0	0	0	0	0	0	54.68	0	0	13.8	0.3	3.6
2025	4	19	9	2	55	0	0	0	0	0	0	0	54.75	0	0	13.8	0.3	3.6
2025	4	19	9	12	55	0	0	0	0	0	0	0	54.82	0	0	13.8	0.3	3.6
2025	4	19	9	22	55	0	0	0	0	0	0	0	54.88	0	0	13.8	0.3	3.6
2025	4	19	9	32	55	0	0	0	0	0	0	0	54.95	0	0	13.8	0.3	3.6
2025	4	19	9	42	55	0	0	0	0	0	0	0	55.04	0	0	13.8	0.3	3.6
2025	4	19	9	52	55	0	0	0	0	0	0	0	55.11	0	0	13.8	0.3	3.6
2025	4	19	10	2	55	0	0	0	0	0	0	0	55.18	0	0	13.6	0.3	3.6
2025	4	19	10	12	55	0	0	0	0	0	0	0	55.27	0	0	13.8	0.3	3.6
2025	4	19	10	22	55	0	0	0	0	0	0	0	55.35	0	0	13.4	0.3	3.6
2025	4	19	10	32	55	0	0	0	0	0	0	0	55.45	0	0	13.6	0.3	3.6
2025	4	19	10	42	55	0	0	0	0	0	0	0	55.53	0	0	13.4	0.3	3.6
2025	4	19	10	52	55	0	0	0	0	0	0	0	55.63	0	0	13.4	0.3	3.6
2025	4	19	11	2	55	0	0	0	0	0	0	0	55.71	0	0	13.4	0.3	3.6
2025	4	19	11	12	55	0	0	0	0	0	0	0	55.8	0	0	13.4	0.3	3.6
2025	4	19	11	22	55	0	0	0	0	0	0	0	55.87	0	0	13.2	0.3	3.6
2025	4	19	11	32	55	0	0	0	0	0	0	0	55.96	0	0	13.2	0.3	3.6
2025	4	19	11	42	55	0	0	0	0	0	0	0	56.05	0	0	13.2	0.3	3.6
2025	4	19	11	52	55	0	0	0	0	0	0	0	56.12	0	0	13.2	0.3	3.6
2025	4	19	12	2	55	0	0	0	0	0	0	0	56.21	0	0	13.4	0.3	3.6
2025	4	19	12	12	55	0	0	0	0	0	0	0	56.28	0	0	13.2	0.3	3.6
2025	4	19	12	22	55	0	0	0	0	0	0	0	56.35	0	0	13.2	0.3	3.6
2025	4	19	12	32	55	0	0	0	0	0	0	0	56.43	0	0	13.2	0.3	3.6
2025	4	19	12	42	55	0	0	0	0	0	0	0	56.52	0	0	13.4	0.3	3.6
2025	4	19	12	52	55	0	0	0	0	0	0	0	56.57	0	0	13.2	0.3	3.6
2025	4	19	13	2	55	0	0	0	0	0	0	0	56.62	0	0	13.2	0.3	3.6
2025	4	19	13	12	55	0	0	0	0	0	0	0	56.68	0	0	13.2	0.3	3.6
2025	4	19	13	22	55	0	0	0	0	0	0	0	56.75	0	0	13.2	0.3	3.6
2025	4	19	13	32	55	0	0	0	0	0	0	0	56.8	0	0	13.2	0.3	3.6
2025	4	19	13	42	55	0	0	0	0	0	0	0	56.82	0	0	13.2	0.3	3.6
2025	4	19	13	52	55	0	0	0	0	0	0	0	56.86	0	0	13.2	0.3	3.6
2025	4	19	14	2	55	0	0	0	0	0	0	0	56.89	0	0	13.2	0.3	3.6
2025	4	19	14	12	55	0	0	0	0	0	0	0	56.93	0	0	13.2	0.3	3.6
2025	4	19	14	22	55	0	0	0	0	0	0	0	56.95	0	0	13.2	0.3	3.6
2025	4	19	14	32	55	0	0	0	0	0	0	0	56.97	0	0	13.2	0.3	3.6
2025	4	19	14	42	55	0	0	0	0	0	0	0	56.98	0	0	13.2	0.3	3.6
2025	4	19	14	52	55	0	0	0	0	0	0	0	56.98	0	0	13.2	0.3	3.6
2025	4	19	15	2	55	0	0	0	0	0	0	0	57	0	0	13.2	0.3	3.6
2025	4	19	15	12	55	0	0	0	0	0	0	0	56.98	0	0	13.2	0.3	3.6
2025	4	19	15	22	55	0	0	0	0	0	0	0	56.98	0	0	13	0.3	3.6
2025	4	19	15	32	55	0	0	0	0	0	0	0	56.97	0	0	13	0.3	3.6
2025	4	19	15	42	55	0	0	0	0	0	0	0	56.95	0	0	13	0.3	3.6
2025	4	19	15	52	55	0	0	0	0	0	0	0	56.93	0	0	13	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	19	16	2	55	0	0	0	0	0	0	0	56.91	0	0	12.4	0.3	3.6
2025	4	19	16	12	55	0	0	0	0	0	0	0	56.88	0	0	12.2	0.3	3.6
2025	4	19	16	22	55	0	0	0	0	0	0	0	56.82	0	0	12	0.3	3.6
2025	4	19	16	32	55	0	0	0	0	0	0	0	56.79	0	0	12	0.3	3.6
2025	4	19	16	42	55	0	0	0	0	0	0	0	56.73	0	0	11.8	0.3	3.6
2025	4	19	16	52	55	0	0	0	0	0	0	0	56.68	0	0	11.6	0.3	3.6
2025	4	19	17	2	55	0	0	0	0	0	0	0	56.61	0	0	11.4	0.3	3.6
2025	4	19	17	12	55	0	0	0	0	0	0	0	56.53	0	0	11.4	0.3	3.6
2025	4	19	17	22	55	0	0	0	0	0	0	0	56.48	0	0	11.4	0.3	3.6
2025	4	19	17	32	55	0	0	0	0	0	0	0	56.41	0	0	11.4	0.3	3.6
2025	4	19	17	42	55	0	0	0	0	0	0	0	56.35	0	0	11.4	0.3	3.6
2025	4	19	17	52	55	0	0	0	0	0	0	0	56.28	0	0	11.4	0.3	3.6
2025	4	19	18	2	55	0	0	0	0	0	0	0	56.21	0	0	11.4	0.3	3.6
2025	4	19	18	12	55	0	0	0	0	0	0	0	56.12	0	0	11.4	0.3	3.6
2025	4	19	18	22	55	0	0	0	0	0	0	0	56.07	0	0	11.4	0.3	3.6
2025	4	19	18	32	55	0	0	0	0	0	0	0	55.98	0	0	11.4	0.3	3.6
2025	4	19	18	42	55	0	0	0	0	0	0	0	55.9	0	0	11.2	0.3	3.6
2025	4	19	18	52	55	0	0	0	0	0	0	0	55.83	0	0	11.2	0.3	3.6
2025	4	19	19	2	55	0	0	0	0	0	0	0	55.74	0	0	11.2	0.3	3.6
2025	4	19	19	12	55	0	0	0	0	0	0	0	55.65	0	0	11.2	0.3	3.6
2025	4	19	19	22	55	0	0	0	0	0	0	0	55.56	0	0	11.4	0.3	3.6
2025	4	19	19	32	55	0	0	0	0	0	0	0	55.49	0	0	11.4	0.3	3.6
2025	4	19	19	42	55	0	0	0	0	0	0	0	55.42	0	0	11.4	0.3	3.6
2025	4	19	19	52	55	0	0	0	0	0	0	0	55.33	0	0	11.4	0.3	3.6
2025	4	19	20	2	55	0	0	0	0	0	0	0	55.26	0	0	11.4	0.3	3.6
2025	4	19	20	12	55	0	0	0	0	0	0	0	55.18	0	0	11.4	0.3	3.6
2025	4	19	20	22	55	0	0	0	0	0	0	0	55.11	0	0	11.4	0.3	3.6
2025	4	19	20	32	55	0	0	0	0	0	0	0	55.02	0	0	11.2	0.3	3.6
2025	4	19	20	42	55	0	0	0	0	0	0	0	54.95	0	0	11.2	0.3	3.6
2025	4	19	20	52	55	0	0	0	0	0	0	0	54.88	0	0	11.2	0.3	3.6
2025	4	19	21	2	55	0	0	0	0	0	0	0	54.81	0	0	11.2	0.3	3.6
2025	4	19	21	12	55	0	0	0	0	0	0	0	54.72	0	0	11.2	0.3	3.6
2025	4	19	21	22	55	0	0	0	0	0	0	0	54.64	0	0	11.2	0.3	3.6
2025	4	19	21	32	55	0	0	0	0	0	0	0	54.57	0	0	11.2	0.3	3.6
2025	4	19	21	42	55	0	0	0	0	0	0	0	54.48	0	0	11.2	0.3	3.6
2025	4	19	21	52	55	0	0	0	0	0	0	0	54.43	0	0	11.2	0.3	3.6
2025	4	19	22	2	55	0	0	0	0	0	0	0	54.36	0	0	11.2	0.3	3.6
2025	4	19	22	12	55	0	0	0	0	0	0	0	54.3	0	0	11.2	0.3	3.6
2025	4	19	22	22	55	0	0	0	0	0	0	0	54.23	0	0	11.2	0.3	3.6
2025	4	19	22	32	55	0	0	0	0	0	0	0	54.18	0	0	11.2	0.3	3.6
2025	4	19	22	42	55	0	0	0	0	0	0	0	54.12	0	0	11.2	0.3	3.6
2025	4	19	22	52	55	0	0	0	0	0	0	0	54.07	0	0	11.2	0.3	3.6
2025	4	19	23	2	55	0	0	0	0	0	0	0	54.03	0	0	11.4	0.3	3.6
2025	4	19	23	12	55	0	0	0	0	0	0	0	54	0	0	11.4	0.3	3.6
2025	4	19	23	22	55	0	0	0	0	0	0	0	53.94	0	0	11.4	0.3	3.6
2025	4	19	23	32	55	0	0	0	0	0	0	0	53.91	0	0	11.4	0.3	3.6
2025	4	19	23	42	55	0	0	0	0	0	0	0	53.87	0	0	11.4	0.3	3.6
2025	4	19	23	52	55	0	0	0	0	0	0	0	53.85	0	0	11.4	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	20	0	2	55	0	0	0	0	0	0	0	53.82	0	0	11.4	0.3	3.6
2025	4	20	0	12	55	0	0	0	0	0	0	0	53.78	0	0	11.4	0.3	3.6
2025	4	20	0	22	55	0	0	0	0	0	0	0	53.76	0	0	11.4	0.3	3.6
2025	4	20	0	32	55	0	0	0	0	0	0	0	53.74	0	0	11.4	0.3	3.6
2025	4	20	0	42	55	0	0	0	0	0	0	0	53.73	0	0	11.4	0.3	3.6
2025	4	20	0	52	55	0	0	0	0	0	0	0	53.71	0	0	11.4	0.3	3.6
2025	4	20	1	2	55	0	0	0	0	0	0	0	53.69	0	0	11.4	0.3	3.6
2025	4	20	1	12	55	0	0	0	0	0	0	0	53.67	0	0	11.4	0.3	3.6
2025	4	20	1	22	55	0	0	0	0	0	0	0	53.67	0	0	11.4	0.3	3.6
2025	4	20	1	32	55	0	0	0	0	0	0	0	53.65	0	0	11.4	0.3	3.6
2025	4	20	1	42	55	0	0	0	0	0	0	0	53.65	0	0	11.4	0.3	3.6
2025	4	20	1	52	55	0	0	0	0	0	0	0	53.65	0	0	11.4	0.3	3.6
2025	4	20	2	2	55	0	0	0	0	0	0	0	53.64	0	0	11.2	0.3	3.6
2025	4	20	2	12	55	0	0	0	0	0	0	0	53.64	0	0	11.2	0.3	3.6
2025	4	20	2	22	55	0	0	0	0	0	0	0	53.64	0	0	11.2	0.3	3.6
2025	4	20	2	32	55	0	0	0	0	0	0	0	53.64	0	0	11.2	0.3	3.6
2025	4	20	2	42	55	0	0	0	0	0	0	0	53.64	0	0	11.2	0.3	3.6
2025	4	20	2	52	55	0	0	0	0	0	0	0	53.62	0	0	11.2	0.3	3.6
2025	4	20	3	2	55	0	0	0	0	0	0	0	53.64	0	0	11.2	0.3	3.6
2025	4	20	3	12	55	0	0	0	0	0	0	0	53.64	0	0	11.2	0.3	3.6
2025	4	20	3	22	55	0	0	0	0	0	0	0	53.64	0	0	11.2	0.3	3.6
2025	4	20	3	32	55	0	0	0	0	0	0	0	53.64	0	0	11.2	0.3	3.6
2025	4	20	3	42	55	0	0	0	0	0	0	0	53.65	0	0	11.2	0.3	3.6
2025	4	20	3	52	55	0	0	0	0	0	0	0	53.65	0	0	11.2	0.3	3.6
2025	4	20	4	2	55	0	0	0	0	0	0	0	53.67	0	0	11.2	0.3	3.6
2025	4	20	4	12	55	0	0	0	0	0	0	0	53.67	0	0	11.2	0.3	3.6
2025	4	20	4	22	55	0	0	0	0	0	0	0	53.69	0	0	11.2	0.3	3.6
2025	4	20	4	32	55	0	0	0	0	0	0	0	53.71	0	0	11.2	0.3	3.6
2025	4	20	4	42	55	0	0	0	0	0	0	0	53.71	0	0	11.2	0.3	3.6
2025	4	20	4	52	55	0	0	0	0	0	0	0	53.73	0	0	11.2	0.3	3.6
2025	4	20	5	2	55	0	0	0	0	0	0	0	53.73	0	0	11.2	0.3	3.6
2025	4	20	5	12	55	0	0	0	0	0	0	0	53.74	0	0	11.2	0.3	3.6
2025	4	20	5	22	55	0	0	0	0	0	0	0	53.74	0	0	11.2	0.3	3.6
2025	4	20	5	32	55	0	0	0	0	0	0	0	53.76	0	0	11.2	0.3	3.6
2025	4	20	5	42	55	0	0	0	0	0	0	0	53.78	0	0	11.2	0.3	3.6
2025	4	20	5	52	55	0	0	0	0	0	0	0	53.78	0	0	11.2	0.3	3.6
2025	4	20	6	2	55	0	0	0	0	0	0	0	53.8	0	0	11.2	0.3	3.6
2025	4	20	6	12	55	0	0	0	0	0	0	0	53.82	0	0	11.4	0.3	3.6
2025	4	20	6	22	55	0	0	0	0	0	0	0	53.83	0	0	11.6	0.3	3.6
2025	4	20	6	32	55	0	0	0	0	0	0	0	53.87	0	0	11.8	0.3	3.6
2025	4	20	6	42	55	0	0	0	0	0	0	0	53.92	0	0	12	0.3	3.6
2025	4	20	6	52	55	0	0	0	0	0	0	0	53.98	0	0	12.2	0.3	3.6
2025	4	20	7	2	55	0	0	0	0	0	0	0	54.03	0	0	12.4	0.3	3.6
2025	4	20	7	12	55	0	0	0	0	0	0	0	54.07	0	0	12.4	0.3	3.6
2025	4	20	7	22	55	0	0	0	0	0	0	0	54.16	0	0	12.6	0.3	3.6
2025	4	20	7	32	55	0	0	0	0	0	0	0	54.23	0	0	12.6	0.3	3.6
2025	4	20	7	42	55	0	0	0	0	0	0	0	54.3	0	0	12.8	0.3	3.6
2025	4	20	7	52	55	0	0	0	0	0	0	0	54.39	0	0	13	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	20	8	2	55	0	0	0	0	0	0	0	54.48	0	0	13.6	0.3	3.6
2025	4	20	8	12	55	0	0	0	0	0	0	0	54.57	0	0	13.8	0.3	3.6
2025	4	20	8	22	55	0	0	0	0	0	0	0	54.68	0	0	13.8	0.3	3.6
2025	4	20	8	32	55	0	0	0	0	0	0	0	54.77	0	0	13.6	0.3	3.6
2025	4	20	8	42	55	0	0	0	0	0	0	0	54.88	0	0	13.6	0.3	3.6
2025	4	20	8	52	55	0	0	0	0	0	0	0	54.97	0	0	13.6	0.3	3.6
2025	4	20	9	2	55	0	0	0	0	0	0	0	55.09	0	0	13.6	0.3	3.6
2025	4	20	9	12	55	0	0	0	0	0	0	0	55.2	0	0	13.6	0.3	3.6
2025	4	20	9	22	55	0	0	0	0	0	0	0	55.31	0	0	13.6	0.3	3.6
2025	4	20	9	32	55	0	0	0	0	0	0	0	55.42	0	0	13.6	0.3	3.6
2025	4	20	9	42	55	0	0	0	0	0	0	0	55.53	0	0	13.2	0.3	3.6
2025	4	20	9	52	55	0	0	0	0	0	0	0	55.65	0	0	13.4	0.3	3.6
2025	4	20	10	2	55	0	0	0	0	0	0	0	55.76	0	0	13.2	0.3	3.6
2025	4	20	10	12	55	0	0	0	0	0	0	0	55.89	0	0	13.4	0.3	3.6
2025	4	20	10	22	55	0	0	0	0	0	0	0	55.99	0	0	13.4	0.3	3.6
2025	4	20	10	32	55	0	0	0	0	0	0	0	56.1	0	0	13.4	0.3	3.6
2025	4	20	10	42	55	0	0	0	0	0	0	0	56.23	0	0	13.4	0.3	3.6
2025	4	20	10	52	55	0	0	0	0	0	0	0	56.34	0	0	13.4	0.3	3.6
2025	4	20	11	2	55	0	0	0	0	0	0	0	56.44	0	0	13.2	0.3	3.6
2025	4	20	11	12	55	0	0	0	0	0	0	0	56.55	0	0	13.2	0.3	3.6
2025	4	20	11	22	55	0	0	0	0	0	0	0	56.66	0	0	13.4	0.3	3.6
2025	4	20	11	32	55	0	0	0	0	0	0	0	56.77	0	0	13.4	0.3	3.6
2025	4	20	11	42	55	0	0	0	0	0	0	0	56.88	0	0	13.4	0.3	3.6
2025	4	20	11	52	55	0	0	0	0	0	0	0	56.95	0	0	13.4	0.3	3.6
2025	4	20	12	2	55	0	0	0	0	0	0	0	57.06	0	0	13.4	0.3	3.6
2025	4	20	12	12	55	0	0	0	0	0	0	0	57.15	0	0	13.4	0.3	3.6
2025	4	20	12	22	55	0	0	0	0	0	0	0	57.24	0	0	13.4	0.3	3.6
2025	4	20	12	32	55	0	0	0	0	0	0	0	57.31	0	0	13.4	0.3	3.6
2025	4	20	12	42	55	0	0	0	0	0	0	0	57.4	0	0	13.4	0.3	3.6
2025	4	20	12	52	55	0	0	0	0	0	0	0	57.47	0	0	13.4	0.3	3.6
2025	4	20	13	2	55	0	0	0	0	0	0	0	57.52	0	0	13.4	0.3	3.6
2025	4	20	13	12	55	0	0	0	0	0	0	0	57.6	0	0	13.6	0.3	3.6
2025	4	20	13	22	55	0	0	0	0	0	0	0	57.67	0	0	13.6	0.3	3.6
2025	4	20	13	32	55	0	0	0	0	0	0	0	57.72	0	0	13.6	0.3	3.6
2025	4	20	13	42	55	0	0	0	0	0	0	0	57.76	0	0	13.6	0.3	3.6
2025	4	20	13	52	55	0	0	0	0	0	0	0	57.81	0	0	13.6	0.3	3.6
2025	4	20	14	2	55	0	0	0	0	0	0	0	57.87	0	0	13.8	0.3	3.6
2025	4	20	14	12	55	0	0	0	0	0	0	0	57.9	0	0	13.8	0.3	3.6
2025	4	20	14	22	55	0	0	0	0	0	0	0	57.9	0	0	13.6	0.3	3.6
2025	4	20	14	32	55	0	0	0	0	0	0	0	57.94	0	0	13.8	0.3	3.6
2025	4	20	14	42	55	0	0	0	0	0	0	0	57.96	0	0	13.8	0.3	3.6
2025	4	20	14	52	55	0	0	0	0	0	0	0	57.97	0	0	13.8	0.3	3.6
2025	4	20	15	2	55	0	0	0	0	0	0	0	57.97	0	0	13.8	0.3	3.6
2025	4	20	15	12	55	0	0	0	0	0	0	0	57.97	0	0	13.6	0.3	3.6
2025	4	20	15	22	55	0	0	0	0	0	0	0	57.97	0	0	13.6	0.3	3.6
2025	4	20	15	32	55	0	0	0	0	0	0	0	57.96	0	0	13.6	0.3	3.6
2025	4	20	15	42	55	0	0	0	0	0	0	0	57.94	0	0	13.6	0.3	3.6
2025	4	20	15	52	55	0	0	0	0	0	0	0	57.92	0	0	13.6	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	20	16	2	55	0	0	0	0	0	0	0	57.9	0	0	13	0.3	3.6
2025	4	20	16	12	55	0	0	0	0	0	0	0	57.87	0	0	12.6	0.3	3.6
2025	4	20	16	22	55	0	0	0	0	0	0	0	57.81	0	0	12.4	0.3	3.6
2025	4	20	16	32	55	0	0	0	0	0	0	0	57.76	0	0	12.4	0.3	3.6
2025	4	20	16	42	55	0	0	0	0	0	0	0	57.72	0	0	12.2	0.3	3.6
2025	4	20	16	52	55	0	0	0	0	0	0	0	57.65	0	0	12	0.3	3.6
2025	4	20	17	2	55	0	0	0	0	0	0	0	57.6	0	0	11.8	0.3	3.6
2025	4	20	17	12	55	0	0	0	0	0	0	0	57.52	0	0	11.8	0.3	3.6
2025	4	20	17	22	55	0	0	0	0	0	0	0	57.45	0	0	11.8	0.3	3.6
2025	4	20	17	32	55	0	0	0	0	0	0	0	57.38	0	0	11.8	0.3	3.6
2025	4	20	17	42	55	0	0	0	0	0	0	0	57.31	0	0	11.8	0.3	3.6
2025	4	20	17	52	55	0	0	0	0	0	0	0	57.24	0	0	11.8	0.3	3.6
2025	4	20	18	2	55	0	0	0	0	0	0	0	57.16	0	0	11.6	0.3	3.6
2025	4	20	18	12	55	0	0	0	0	0	0	0	57.09	0	0	11.6	0.3	3.6
2025	4	20	18	22	55	0	0	0	0	0	0	0	57.02	0	0	11.6	0.3	3.6
2025	4	20	18	32	55	0	0	0	0	0	0	0	56.93	0	0	11.6	0.3	3.6
2025	4	20	18	42	55	0	0	0	0	0	0	0	56.86	0	0	11.6	0.3	3.6
2025	4	20	18	52	55	0	0	0	0	0	0	0	56.79	0	0	11.6	0.3	3.6
2025	4	20	19	2	55	0	0	0	0	0	0	0	56.7	0	0	11.6	0.3	3.6
2025	4	20	19	12	55	0	0	0	0	0	0	0	56.61	0	0	11.6	0.3	3.6
2025	4	20	19	22	55	0	0	0	0	0	0	0	56.53	0	0	11.6	0.3	3.6
2025	4	20	19	32	55	0	0	0	0	0	0	0	56.44	0	0	11.6	0.3	3.6
2025	4	20	19	42	55	0	0	0	0	0	0	0	56.34	0	0	11.6	0.3	3.6
2025	4	20	19	52	55	0	0	0	0	0	0	0	56.26	0	0	11.6	0.3	3.6
2025	4	20	20	2	55	0	0	0	0	0	0	0	56.16	0	0	11.6	0.3	3.6
2025	4	20	20	12	55	0	0	0	0	0	0	0	56.08	0	0	11.6	0.3	3.6
2025	4	20	20	22	55	0	0	0	0	0	0	0	55.99	0	0	11.6	0.3	3.6
2025	4	20	20	32	55	0	0	0	0	0	0	0	55.92	0	0	11.6	0.3	3.6
2025	4	20	20	42	55	0	0	0	0	0	0	0	55.81	0	0	11.6	0.3	3.6
2025	4	20	20	52	55	0	0	0	0	0	0	0	55.72	0	0	11.6	0.3	3.6
2025	4	20	21	2	55	0	0	0	0	0	0	0	55.63	0	0	11.6	0.3	3.6
2025	4	20	21	12	55	0	0	0	0	0	0	0	55.58	0	0	11.6	0.3	3.6
2025	4	20	21	22	55	0	0	0	0	0	0	0	55.51	0	0	11.6	0.3	3.6
2025	4	20	21	32	55	0	0	0	0	0	0	0	55.45	0	0	11.6	0.3	3.6
2025	4	20	21	42	55	0	0	0	0	0	0	0	55.4	0	0	11.6	0.3	3.6
2025	4	20	21	52	55	0	0	0	0	0	0	0	55.35	0	0	11.6	0.3	3.6
2025	4	20	22	2	55	0	0	0	0	0	0	0	55.29	0	0	11.6	0.3	3.6
2025	4	20	22	12	55	0	0	0	0	0	0	0	55.24	0	0	11.6	0.3	3.6
2025	4	20	22	22	55	0	0	0	0	0	0	0	55.2	0	0	11.6	0.3	3.6
2025	4	20	22	32	55	0	0	0	0	0	0	0	55.15	0	0	11.6	0.3	3.6
2025	4	20	22	42	55	0	0	0	0	0	0	0	55.09	0	0	11.6	0.3	3.6
2025	4	20	22	52	55	0	0	0	0	0	0	0	55.04	0	0	11.6	0.3	3.6
2025	4	20	23	2	55	0	0	0	0	0	0	0	54.99	0	0	11.6	0.3	3.6
2025	4	20	23	12	55	0	0	0	0	0	0	0	54.95	0	0	11.6	0.3	3.6
2025	4	20	23	22	55	0	0	0	0	0	0	0	54.91	0	0	11.6	0.3	3.6
2025	4	20	23	32	55	0	0	0	0	0	0	0	54.88	0	0	11.6	0.3	3.6
2025	4	20	23	42	55	0	0	0	0	0	0	0	54.84	0	0	11.6	0.3	3.6
2025	4	20	23	52	55	0	0	0	0	0	0	0	54.81	0	0	11.6	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	21	0	2	55	0	0	0	0	0	0	0	54.77	0	0	11.6	0.3	3.6
2025	4	21	0	12	55	0	0	0	0	0	0	0	54.75	0	0	11.6	0.3	3.6
2025	4	21	0	22	55	0	0	0	0	0	0	0	54.73	0	0	11.6	0.3	3.6
2025	4	21	0	32	55	0	0	0	0	0	0	0	54.72	0	0	11.6	0.3	3.6
2025	4	21	0	42	55	0	0	0	0	0	0	0	54.7	0	0	11.6	0.3	3.6
2025	4	21	0	52	55	0	0	0	0	0	0	0	54.68	0	0	11.6	0.3	3.6
2025	4	21	1	2	55	0	0	0	0	0	0	0	54.68	0	0	11.6	0.3	3.6
2025	4	21	1	12	55	0	0	0	0	0	0	0	54.66	0	0	11.6	0.3	3.6
2025	4	21	1	22	55	0	0	0	0	0	0	0	54.66	0	0	11.6	0.3	3.6
2025	4	21	1	32	55	0	0	0	0	0	0	0	54.66	0	0	11.6	0.3	3.6
2025	4	21	1	42	55	0	0	0	0	0	0	0	54.66	0	0	11.6	0.3	3.6
2025	4	21	1	52	55	0	0	0	0	0	0	0	54.66	0	0	11.6	0.3	3.6
2025	4	21	2	2	55	0	0	0	0	0	0	0	54.66	0	0	11.6	0.3	3.6
2025	4	21	2	12	55	0	0	0	0	0	0	0	54.66	0	0	11.6	0.3	3.6
2025	4	21	2	22	55	0	0	0	0	0	0	0	54.66	0	0	11.6	0.3	3.6
2025	4	21	2	32	55	0	0	0	0	0	0	0	54.68	0	0	11.6	0.3	3.6
2025	4	21	2	42	55	0	0	0	0	0	0	0	54.68	0	0	11.4	0.3	3.6
2025	4	21	2	52	55	0	0	0	0	0	0	0	54.68	0	0	11.4	0.3	3.6
2025	4	21	3	2	55	0	0	0	0	0	0	0	54.68	0	0	11.4	0.3	3.6
2025	4	21	3	12	55	0	0	0	0	0	0	0	54.7	0	0	11.4	0.3	3.6
2025	4	21	3	22	55	0	0	0	0	0	0	0	54.7	0	0	11.4	0.3	3.6
2025	4	21	3	32	55	0	0	0	0	0	0	0	54.72	0	0	11.4	0.3	3.6
2025	4	21	3	42	55	0	0	0	0	0	0	0	54.72	0	0	11.4	0.3	3.6
2025	4	21	3	52	55	0	0	0	0	0	0	0	54.72	0	0	11.4	0.3	3.6
2025	4	21	4	2	55	0	0	0	0	0	0	0	54.72	0	0	11.4	0.3	3.6
2025	4	21	4	12	55	0	0	0	0	0	0	0	54.73	0	0	11.4	0.3	3.6
2025	4	21	4	22	55	0	0	0	0	0	0	0	54.73	0	0	11.4	0.3	3.6
2025	4	21	4	32	55	0	0	0	0	0	0	0	54.75	0	0	11.4	0.3	3.6
2025	4	21	4	42	55	0	0	0	0	0	0	0	54.77	0	0	11.4	0.3	3.6
2025	4	21	4	52	55	0	0	0	0	0	0	0	54.77	0	0	11.4	0.3	3.6
2025	4	21	5	2	55	0	0	0	0	0	0	0	54.79	0	0	11.4	0.3	3.6
2025	4	21	5	12	55	0	0	0	0	0	0	0	54.79	0	0	11.4	0.3	3.6
2025	4	21	5	22	55	0	0	0	0	0	0	0	54.79	0	0	11.4	0.3	3.6
2025	4	21	5	32	55	0	0	0	0	0	0	0	54.81	0	0	11.4	0.3	3.6
2025	4	21	5	42	55	0	0	0	0	0	0	0	54.81	0	0	11.4	0.3	3.6
2025	4	21	5	52	55	0	0	0	0	0	0	0	54.82	0	0	11.4	0.3	3.6
2025	4	21	6	2	55	0	0	0	0	0	0	0	54.84	0	0	11.4	0.3	3.6
2025	4	21	6	12	55	0	0	0	0	0	0	0	54.86	0	0	11.6	0.3	3.6
2025	4	21	6	22	55	0	0	0	0	0	0	0	54.9	0	0	11.8	0.3	3.6
2025	4	21	6	32	55	0	0	0	0	0	0	0	54.93	0	0	12	0.3	3.6
2025	4	21	6	42	55	0	0	0	0	0	0	0	54.99	0	0	12	0.3	3.6
2025	4	21	6	52	55	0	0	0	0	0	0	0	55.04	0	0	12.2	0.3	3.6
2025	4	21	7	2	55	0	0	0	0	0	0	0	55.11	0	0	12.4	0.3	3.6
2025	4	21	7	12	55	0	0	0	0	0	0	0	55.18	0	0	12.4	0.3	3.6
2025	4	21	7	22	55	0	0	0	0	0	0	0	55.26	0	0	12.6	0.3	3.6
2025	4	21	7	32	55	0	0	0	0	0	0	0	55.33	0	0	12.8	0.3	3.6
2025	4	21	7	42	55	0	0	0	0	0	0	0	55.4	0	0	13.2	0.3	3.6
2025	4	21	7	52	55	0	0	0	0	0	0	0	55.51	0	0	13.4	0.3	3.6

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	21	8	2	55	0	0	0	0	0	0	0	55.58	0	0	13.6	0.3	3.6
2025	4	21	8	12	55	0	0	0	0	0	0	0	55.67	0	0	13.6	0.3	3.6
2025	4	21	8	22	55	0	0	0	0	0	0	0	55.78	0	0	13.8	0.3	3.6
2025	4	21	8	32	55	0	0	0	0	0	0	0	55.87	0	0	13.8	0.3	3.6
2025	4	21	8	42	55	0	0	0	0	0	0	0	55.96	0	0	13.8	0.3	3.6
2025	4	21	8	52	55	0	0	0	0	0	0	0	56.07	0	0	13.8	0.3	3.6
2025	4	21	9	2	55	0	0	0	0	0	0	0	56.17	0	0	13.8	0.3	3.6
2025	4	21	9	12	55	0	0	0	0	0	0	0	56.26	0	0	13.8	0.3	3.6
2025	4	21	9	22	55	0	0	0	0	0	0	0	56.39	0	0	13.6	0.3	3.6
2025	4	21	16	15	24	0	0	0	0	0	0	0	14.87	0	0	12.4	0.1	1.1
2025	4	21	16	25	24	0	0	0	0	0	0	0	14.88	0	0	13.4	0.1	1.1
2025	4	21	16	35	24	0	0	0	0	0	0	0	14.89	0	0	13.6	0.1	1.1
2025	4	21	16	45	24	0	0	0	0	0	0	0	14.88	0	0	13.2	0.1	1.1
2025	4	21	16	55	24	0	0	0	0	0	0	0	14.84	0	0	12.4	0.1	1.1
2025	4	21	17	5	24	0	0	0	0	0	0	0	14.81	0	0	12	0.1	1.1
2025	4	21	17	15	24	0	0	0	0	0	0	0	14.78	0	0	12	0.1	1.1
2025	4	21	17	25	24	0	0	0	0	0	0	0	14.75	0	0	12	0.1	1.1
2025	4	21	17	35	24	0	0	0	0	0	0	0	14.74	0	0	12	0.1	1.1
2025	4	21	17	45	24	0	0	0	0	0	0	0	14.71	0	0	12	0.1	1.1
2025	4	21	17	55	24	0	0	0	0	0	0	0	14.68	0	0	12	0.1	1.1
2025	4	21	18	5	24	0	0	0	0	0	0	0	14.65	0	0	12	0.1	1.1
2025	4	21	18	15	24	0	0	0	0	0	0	0	14.62	0	0	11.8	0.1	1.1
2025	4	21	18	25	24	0	0	0	0	0	0	0	14.59	0	0	11.8	0.1	1.1
2025	4	21	18	35	24	0	0	0	0	0	0	0	14.54	0	0	11.8	0.1	1.1
2025	4	21	18	45	24	0	0	0	0	0	0	0	14.51	0	0	11.8	0.1	1.1
2025	4	21	18	55	24	0	0	0	0	0	0	0	14.48	0	0	11.8	0.1	1.1
2025	4	21	19	5	24	0	0	0	0	0	0	0	14.43	0	0	11.8	0.1	1.1
2025	4	21	19	15	24	0	0	0	0	0	0	0	14.39	0	0	11.8	0.1	1.1
2025	4	21	19	25	24	0	0	0	0	0	0	0	14.34	0	0	11.6	0.1	1.1
2025	4	21	19	35	24	0	0	0	0	0	0	0	14.29	0	0	11.6	0.1	1.1
2025	4	21	19	45	24	0	0	0	0	0	0	0	14.24	0	0	11.6	0.1	1.1
2025	4	21	19	55	24	0	0	0	0	0	0	0	14.2	0	0	11.6	0.1	1.1
2025	4	21	20	5	24	0	0	0	0	0	0	0	14.15	0	0	11.6	0.1	1.1
2025	4	21	20	15	24	0	0	0	0	0	0	0	14.09	0	0	11.6	0.1	1.1
2025	4	21	20	25	24	0	0	0	0	0	0	0	14.05	0	0	11.6	0.1	1.1
2025	4	21	20	35	24	0	0	0	0	0	0	0	14.01	0	0	11.6	0.1	1.1
2025	4	21	20	45	24	0	0	0	0	0	0	0	13.96	0	0	11.6	0.1	1.1
2025	4	21	20	55	24	0	0	0	0	0	0	0	13.91	0	0	11.6	0.1	1.1
2025	4	21	21	5	24	0	0	0	0	0	0	0	13.87	0	0	11.6	0.1	1.1
2025	4	21	21	15	24	0	0	0	0	0	0	0	13.82	0	0	11.6	0.1	1.1
2025	4	21	21	25	24	0	0	0	0	0	0	0	13.78	0	0	11.6	0.1	1.1
2025	4	21	21	35	24	0	0	0	0	0	0	0	13.73	0	0	11.6	0.1	1.1
2025	4	21	21	45	24	0	0	0	0	0	0	0	13.69	0	0	11.6	0.1	1.1
2025	4	21	21	55	24	0	0	0	0	0	0	0	13.65	0	0	11.6	0.1	1.1
2025	4	21	22	5	24	0	0	0	0	0	0	0	13.61	0	0	11.6	0.1	1.1
2025	4	21	22	15	24	0	0	0	0	0	0	0	13.57	0	0	11.6	0.1	1.1
2025	4	21	22	25	24	0	0	0	0	0	0	0	13.53	0	0	11.6	0.1	1.1
2025	4	21	22	35	24	0	0	0	0	0	0	0	13.51	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	21	22	45	24	0	0	0	0	0	0	0	13.47	0	0	11.6	0.1	1.1
2025	4	21	22	55	24	0	0	0	0	0	0	0	13.44	0	0	11.6	0.1	1.1
2025	4	21	23	5	24	0	0	0	0	0	0	0	13.42	0	0	11.6	0.1	1.1
2025	4	21	23	15	24	0	0	0	0	0	0	0	13.38	0	0	11.6	0.1	1.1
2025	4	21	23	25	24	0	0	0	0	0	0	0	13.36	0	0	11.6	0.1	1.1
2025	4	21	23	35	24	0	0	0	0	0	0	0	13.33	0	0	11.6	0.1	1.1
2025	4	21	23	45	24	0	0	0	0	0	0	0	13.3	0	0	11.6	0.1	1.1
2025	4	21	23	55	24	0	0	0	0	0	0	0	13.28	0	0	11.6	0.1	1.1
2025	4	22	0	5	24	0	0	0	0	0	0	0	13.26	0	0	11.6	0.1	1.1
2025	4	22	0	15	24	0	0	0	0	0	0	0	13.23	0	0	11.6	0.1	1.1
2025	4	22	0	25	24	0	0	0	0	0	0	0	13.22	0	0	11.6	0.1	1.1
2025	4	22	0	35	24	0	0	0	0	0	0	0	13.2	0	0	11.6	0.1	1.1
2025	4	22	0	45	24	0	0	0	0	0	0	0	13.19	0	0	11.6	0.1	1.1
2025	4	22	0	55	24	0	0	0	0	0	0	0	13.17	0	0	11.6	0.1	1.1
2025	4	22	1	5	24	0	0	0	0	0	0	0	13.16	0	0	11.6	0.1	1.1
2025	4	22	1	15	24	0	0	0	0	0	0	0	13.15	0	0	11.6	0.1	1.1
2025	4	22	1	25	24	0	0	0	0	0	0	0	13.14	0	0	11.6	0.1	1.1
2025	4	22	1	35	24	0	0	0	0	0	0	0	13.14	0	0	11.6	0.1	1.1
2025	4	22	1	45	24	0	0	0	0	0	0	0	13.13	0	0	11.6	0.1	1.1
2025	4	22	1	55	24	0	0	0	0	0	0	0	13.14	0	0	11.6	0.1	1.1
2025	4	22	2	5	24	0	0	0	0	0	0	0	13.13	0	0	11.6	0.1	1.1
2025	4	22	2	15	24	0	0	0	0	0	0	0	13.14	0	0	11.6	0.1	1.1
2025	4	22	2	25	24	0	0	0	0	0	0	0	13.15	0	0	11.6	0.1	1.1
2025	4	22	2	35	24	0	0	0	0	0	0	0	13.15	0	0	11.4	0.1	1.1
2025	4	22	2	45	24	0	0	0	0	0	0	0	13.16	0	0	11.4	0.1	1.1
2025	4	22	2	55	24	0	0	0	0	0	0	0	13.16	0	0	11.4	0.1	1.1
2025	4	22	3	5	24	0	0	0	0	0	0	0	13.17	0	0	11.4	0.1	1.1
2025	4	22	3	15	24	0	0	0	0	0	0	0	13.18	0	0	11.4	0.1	1.1
2025	4	22	3	25	24	0	0	0	0	0	0	0	13.19	0	0	11.6	0.1	1.1
2025	4	22	3	35	24	0	0	0	0	0	0	0	13.19	0	0	11.6	0.1	1.1
2025	4	22	3	45	24	0	0	0	0	0	0	0	13.2	0	0	11.6	0.1	1.1
2025	4	22	3	55	24	0	0	0	0	0	0	0	13.21	0	0	11.6	0.1	1.1
2025	4	22	4	5	24	0	0	0	0	0	0	0	13.21	0	0	11.6	0.1	1.1
2025	4	22	4	15	24	0	0	0	0	0	0	0	13.22	0	0	11.6	0.1	1.1
2025	4	22	4	25	24	0	0	0	0	0	0	0	13.22	0	0	11.6	0.1	1.1
2025	4	22	4	35	24	0	0	0	0	0	0	0	13.23	0	0	11.6	0.1	1.1
2025	4	22	4	45	24	0	0	0	0	0	0	0	13.24	0	0	11.6	0.1	1.1
2025	4	22	4	55	24	0	0	0	0	0	0	0	13.24	0	0	11.6	0.1	1.1
2025	4	22	5	5	24	0	0	0	0	0	0	0	13.25	0	0	11.6	0.1	1.1
2025	4	22	5	15	24	0	0	0	0	0	0	0	13.25	0	0	11.6	0.1	1.1
2025	4	22	5	25	24	0	0	0	0	0	0	0	13.26	0	0	11.6	0.1	1.1
2025	4	22	5	35	24	0	0	0	0	0	0	0	13.26	0	0	11.6	0.1	1.1
2025	4	22	5	45	24	0	0	0	0	0	0	0	13.27	0	0	11.6	0.1	1.1
2025	4	22	5	55	24	0	0	0	0	0	0	0	13.27	0	0	11.6	0.1	1.1
2025	4	22	6	5	24	0	0	0	0	0	0	0	13.27	0	0	11.6	0.1	1.1
2025	4	22	6	15	24	0	0	0	0	0	0	0	13.27	0	0	11.6	0.1	1.1
2025	4	22	6	25	24	0	0	0	0	0	0	0	13.28	0	0	11.6	0.1	1.1
2025	4	22	6	35	24	0	0	0	0	0	0	0	13.28	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	22	6	45	24	0	0	0	0	0	0	0	13.29	0	0	11.6	0.1	1.1
2025	4	22	6	55	24	0	0	0	0	0	0	0	13.29	0	0	11.6	0.1	1.1
2025	4	22	7	5	24	0	0	0	0	0	0	0	13.3	0	0	11.6	0.1	1.1
2025	4	22	7	15	24	0	0	0	0	0	0	0	13.31	0	0	11.8	0.1	1.1
2025	4	22	7	25	24	0	0	0	0	0	0	0	13.32	0	0	11.8	0.1	1.1
2025	4	22	7	35	24	0	0	0	0	0	0	0	13.34	0	0	12	0.1	1.1
2025	4	22	7	45	24	0	0	0	0	0	0	0	13.37	0	0	12.2	0.1	1.1
2025	4	22	7	55	24	0	0	0	0	0	0	0	13.4	0	0	12.4	0.1	1.1
2025	4	22	8	5	24	0	0	0	0	0	0	0	13.43	0	0	12.6	0.1	1.1
2025	4	22	8	15	24	0	0	0	0	0	0	0	13.47	0	0	12.6	0.1	1.1
2025	4	22	8	25	24	0	0	0	0	0	0	0	13.51	0	0	12.6	0.1	1.1
2025	4	22	8	35	24	0	0	0	0	0	0	0	13.56	0	0	12.8	0.1	1.1
2025	4	22	8	45	24	0	0	0	0	0	0	0	13.6	0	0	12.8	0.1	1.1
2025	4	22	8	55	24	0	0	0	0	0	0	0	13.65	0	0	13	0.1	1.1
2025	4	22	9	5	24	0	0	0	0	0	0	0	13.69	0	0	13	0.1	1.1
2025	4	22	9	15	24	0	0	0	0	0	0	0	13.75	0	0	13	0.1	1.1
2025	4	22	9	25	24	0	0	0	0	0	0	0	13.8	0	0	13.2	0.1	1.1
2025	4	22	9	35	24	0	0	0	0	0	0	0	13.85	0	0	13.8	0.1	1.1
2025	4	22	9	45	24	0	0	0	0	0	0	0	13.91	0	0	13.4	0.1	1.1
2025	4	22	9	55	24	0	0	0	0	0	0	0	13.96	0	0	13.8	0.1	1.1
2025	4	22	10	5	24	0	0	0	0	0	0	0	14.03	0	0	13.6	0.1	1.1
2025	4	22	10	15	24	0	0	0	0	0	0	0	14.08	0	0	13.4	0.1	1.1
2025	4	22	10	25	24	0	0	0	0	0	0	0	14.14	0	0	13.4	0.1	1.1
2025	4	22	10	35	24	0	0	0	0	0	0	0	14.2	0	0	13.4	0.1	1.1
2025	4	22	10	45	24	0	0	0	0	0	0	0	14.26	0	0	13.4	0.1	1.1
2025	4	22	10	55	24	0	0	0	0	0	0	0	14.32	0	0	13.2	0.1	1.1
2025	4	22	11	5	24	0	0	0	0	0	0	0	14.38	0	0	13.2	0.1	1.1
2025	4	22	11	15	24	0	0	0	0	0	0	0	14.45	0	0	13.2	0.1	1.1
2025	4	22	11	25	24	0	0	0	0	0	0	0	14.51	0	0	13.2	0.1	1.1
2025	4	22	11	35	24	0	0	0	0	0	0	0	14.57	0	0	13.2	0.1	1.1
2025	4	22	11	45	24	0	0	0	0	0	0	0	14.64	0	0	13.2	0.1	1.1
2025	4	22	11	55	24	0	0	0	0	0	0	0	14.69	0	0	13.2	0.1	1.1
2025	4	22	12	5	24	0	0	0	0	0	0	0	14.76	0	0	13.2	0.1	1.1
2025	4	22	12	15	24	0	0	0	0	0	0	0	14.81	0	0	13.4	0.1	1.1
2025	4	22	12	25	24	0	0	0	0	0	0	0	14.87	0	0	13.4	0.1	1.1
2025	4	22	12	35	24	0	0	0	0	0	0	0	14.92	0	0	13.4	0.1	1.1
2025	4	22	12	45	24	0	0	0	0	0	0	0	14.95	0	0	13.4	0.1	1.1
2025	4	22	12	55	24	0	0	0	0	0	0	0	14.98	0	0	13.4	0.1	1.1
2025	4	22	13	5	24	0	0	0	0	0	0	0	15.05	0	0	13.4	0.1	1.1
2025	4	22	13	15	24	0	0	0	0	0	0	0	15.11	0	0	13.4	0.1	1.1
2025	4	22	13	25	24	0	0	0	0	0	0	0	15.16	0	0	13.4	0.1	1.1
2025	4	22	13	35	24	0	0	0	0	0	0	0	15.2	0	0	13.4	0.1	1.1
2025	4	22	13	45	24	0	0	0	0	0	0	0	15.26	0	0	13.4	0.1	1.1
2025	4	22	13	55	24	0	0	0	0	0	0	0	15.3	0	0	13.2	0.1	1.1
2025	4	22	14	5	24	0	0	0	0	0	0	0	15.33	0	0	13.2	0.1	1.1
2025	4	22	14	15	24	0	0	0	0	0	0	0	15.37	0	0	13.2	0.1	1.1
2025	4	22	14	25	24	0	0	0	0	0	0	0	15.41	0	0	13.2	0.1	1.1
2025	4	22	14	35	24	0	0	0	0	0	0	0	15.43	0	0	13.2	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	22	14	45	24	0	0	0	0	0	0	0	15.46	0	0	13.2	0.1	1.1
2025	4	22	14	55	24	0	0	0	0	0	0	0	15.41	0	0	13	0.1	1.1
2025	4	22	15	5	24	0	0	0	0	0	0	0	15.44	0	0	13.2	0.1	1.1
2025	4	22	15	15	24	0	0	0	0	0	0	0	15.45	0	0	13.2	0.1	1.1
2025	4	22	15	25	24	0	0	0	0	0	0	0	15.47	0	0	13.2	0.1	1.1
2025	4	22	15	35	24	0	0	0	0	0	0	0	15.49	0	0	13.2	0.1	1.1
2025	4	22	15	45	24	0	0	0	0	0	0	0	15.5	0	0	13.2	0.1	1.1
2025	4	22	15	55	24	0	0	0	0	0	0	0	15.5	0	0	13	0.1	1.1
2025	4	22	16	5	24	0	0	0	0	0	0	0	15.49	0	0	13	0.1	1.1
2025	4	22	16	15	24	0	0	0	0	0	0	0	15.48	0	0	13	0.1	1.1
2025	4	22	16	25	24	0	0	0	0	0	0	0	15.43	0	0	12.4	0.1	1.1
2025	4	22	16	35	24	0	0	0	0	0	0	0	15.41	0	0	12.4	0.1	1.1
2025	4	22	16	45	24	0	0	0	0	0	0	0	15.38	0	0	12.4	0.1	1.1
2025	4	22	16	55	24	0	0	0	0	0	0	0	15.36	0	0	12.2	0.1	1.1
2025	4	22	17	5	24	0	0	0	0	0	0	0	15.34	0	0	12.2	0.1	1.1
2025	4	22	17	15	24	0	0	0	0	0	0	0	15.32	0	0	12.2	0.1	1.1
2025	4	22	17	25	24	0	0	0	0	0	0	0	15.32	0	0	12.2	0.1	1.1
2025	4	22	17	35	24	0	0	0	0	0	0	0	15.31	0	0	12.2	0.1	1.1
2025	4	22	17	45	24	0	0	0	0	0	0	0	15.29	0	0	12.2	0.1	1.1
2025	4	22	17	55	24	0	0	0	0	0	0	0	15.27	0	0	12	0.1	1.1
2025	4	22	18	5	24	0	0	0	0	0	0	0	15.24	0	0	12	0.1	1.1
2025	4	22	18	15	24	0	0	0	0	0	0	0	15.21	0	0	12	0.1	1.1
2025	4	22	18	25	24	0	0	0	0	0	0	0	15.17	0	0	12	0.1	1.1
2025	4	22	18	35	24	0	0	0	0	0	0	0	15.15	0	0	11.8	0.1	1.1
2025	4	22	18	45	24	0	0	0	0	0	0	0	15.1	0	0	11.8	0.1	1.1
2025	4	22	18	55	24	0	0	0	0	0	0	0	15.07	0	0	11.8	0.1	1.1
2025	4	22	19	5	24	0	0	0	0	0	0	0	15.02	0	0	11.8	0.1	1.1
2025	4	22	19	15	24	0	0	0	0	0	0	0	14.99	0	0	11.8	0.1	1.1
2025	4	22	19	25	24	0	0	0	0	0	0	0	14.95	0	0	11.8	0.1	1.1
2025	4	22	19	35	24	0	0	0	0	0	0	0	14.91	0	0	11.8	0.1	1.1
2025	4	22	19	45	24	0	0	0	0	0	0	0	14.86	0	0	11.8	0.1	1.1
2025	4	22	19	55	24	0	0	0	0	0	0	0	14.82	0	0	11.8	0.1	1.1
2025	4	22	20	5	24	0	0	0	0	0	0	0	14.77	0	0	11.8	0.1	1.1
2025	4	22	20	15	24	0	0	0	0	0	0	0	14.72	0	0	11.8	0.1	1.1
2025	4	22	20	25	24	0	0	0	0	0	0	0	14.68	0	0	11.8	0.1	1.1
2025	4	22	20	35	24	0	0	0	0	0	0	0	14.63	0	0	11.8	0.1	1.1
2025	4	22	20	45	24	0	0	0	0	0	0	0	14.58	0	0	11.8	0.1	1.1
2025	4	22	20	55	24	0	0	0	0	0	0	0	14.54	0	0	11.8	0.1	1.1
2025	4	22	21	5	24	0	0	0	0	0	0	0	14.49	0	0	11.8	0.1	1.1
2025	4	22	21	15	24	0	0	0	0	0	0	0	14.45	0	0	11.8	0.1	1.1
2025	4	22	21	25	24	0	0	0	0	0	0	0	14.4	0	0	11.8	0.1	1.1
2025	4	22	21	35	24	0	0	0	0	0	0	0	14.36	0	0	11.8	0.1	1.1
2025	4	22	21	45	24	0	0	0	0	0	0	0	14.32	0	0	11.8	0.1	1.1
2025	4	22	21	55	24	0	0	0	0	0	0	0	14.28	0	0	11.8	0.1	1.1
2025	4	22	22	5	24	0	0	0	0	0	0	0	14.24	0	0	11.8	0.1	1.1
2025	4	22	22	15	24	0	0	0	0	0	0	0	14.19	0	0	11.8	0.1	1.1
2025	4	22	22	25	24	0	0	0	0	0	0	0	14.17	0	0	11.8	0.1	1.1
2025	4	22	22	35	24	0	0	0	0	0	0	0	14.14	0	0	11.8	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	22	22	45	24	0	0	0	0	0	0	0	14.11	0	0	11.8	0.1	1.1
2025	4	22	22	55	24	0	0	0	0	0	0	0	14.09	0	0	11.8	0.1	1.1
2025	4	22	23	5	24	0	0	0	0	0	0	0	14.06	0	0	11.8	0.1	1.1
2025	4	22	23	15	24	0	0	0	0	0	0	0	14.04	0	0	11.8	0.1	1.1
2025	4	22	23	25	24	0	0	0	0	0	0	0	14.02	0	0	11.6	0.1	1.1
2025	4	22	23	35	24	0	0	0	0	0	0	0	14	0	0	11.6	0.1	1.1
2025	4	22	23	45	24	0	0	0	0	0	0	0	13.98	0	0	11.6	0.1	1.1
2025	4	22	23	55	24	0	0	0	0	0	0	0	13.96	0	0	11.6	0.1	1.1
2025	4	23	0	5	24	0	0	0	0	0	0	0	13.94	0	0	11.6	0.1	1.1
2025	4	23	0	15	24	0	0	0	0	0	0	0	13.93	0	0	11.6	0.1	1.1
2025	4	23	0	25	24	0	0	0	0	0	0	0	13.91	0	0	11.6	0.1	1.1
2025	4	23	0	35	24	0	0	0	0	0	0	0	13.89	0	0	11.6	0.1	1.1
2025	4	23	0	45	24	0	0	0	0	0	0	0	13.88	0	0	11.6	0.1	1.1
2025	4	23	0	55	24	0	0	0	0	0	0	0	13.86	0	0	11.6	0.1	1.1
2025	4	23	1	5	24	0	0	0	0	0	0	0	13.86	0	0	11.6	0.1	1.1
2025	4	23	1	15	24	0	0	0	0	0	0	0	13.85	0	0	11.6	0.1	1.1
2025	4	23	1	25	24	0	0	0	0	0	0	0	13.85	0	0	11.6	0.1	1.1
2025	4	23	1	35	24	0	0	0	0	0	0	0	13.84	0	0	11.6	0.1	1.1
2025	4	23	1	45	24	0	0	0	0	0	0	0	13.84	0	0	11.6	0.1	1.1
2025	4	23	1	55	24	0	0	0	0	0	0	0	13.84	0	0	11.6	0.1	1.1
2025	4	23	2	5	24	0	0	0	0	0	0	0	13.84	0	0	11.6	0.1	1.1
2025	4	23	2	15	24	0	0	0	0	0	0	0	13.84	0	0	11.6	0.1	1.1
2025	4	23	2	25	24	0	0	0	0	0	0	0	13.84	0	0	11.6	0.1	1.1
2025	4	23	2	35	24	0	0	0	0	0	0	0	13.85	0	0	11.6	0.1	1.1
2025	4	23	2	45	24	0	0	0	0	0	0	0	13.85	0	0	11.6	0.1	1.1
2025	4	23	2	55	24	0	0	0	0	0	0	0	13.86	0	0	11.6	0.1	1.1
2025	4	23	3	5	24	0	0	0	0	0	0	0	13.86	0	0	11.6	0.1	1.1
2025	4	23	3	15	24	0	0	0	0	0	0	0	13.87	0	0	11.6	0.1	1.1
2025	4	23	3	25	24	0	0	0	0	0	0	0	13.88	0	0	11.6	0.1	1.1
2025	4	23	3	35	24	0	0	0	0	0	0	0	13.88	0	0	11.6	0.1	1.1
2025	4	23	3	45	24	0	0	0	0	0	0	0	13.89	0	0	11.6	0.1	1.1
2025	4	23	3	55	24	0	0	0	0	0	0	0	13.9	0	0	11.6	0.1	1.1
2025	4	23	4	5	24	0	0	0	0	0	0	0	13.9	0	0	11.6	0.1	1.1
2025	4	23	4	15	24	0	0	0	0	0	0	0	13.91	0	0	11.6	0.1	1.1
2025	4	23	4	25	24	0	0	0	0	0	0	0	13.92	0	0	11.6	0.1	1.1
2025	4	23	4	35	24	0	0	0	0	0	0	0	13.93	0	0	11.6	0.1	1.1
2025	4	23	4	45	24	0	0	0	0	0	0	0	13.94	0	0	11.6	0.1	1.1
2025	4	23	4	55	24	0	0	0	0	0	0	0	13.95	0	0	11.6	0.1	1.1
2025	4	23	5	5	24	0	0	0	0	0	0	0	13.95	0	0	11.6	0.1	1.1
2025	4	23	5	15	24	0	0	0	0	0	0	0	13.96	0	0	11.6	0.1	1.1
2025	4	23	5	25	24	0	0	0	0	0	0	0	13.97	0	0	11.6	0.1	1.1
2025	4	23	5	35	24	0	0	0	0	0	0	0	13.97	0	0	11.6	0.1	1.1
2025	4	23	5	45	24	0	0	0	0	0	0	0	13.98	0	0	11.6	0.1	1.1
2025	4	23	5	55	24	0	0	0	0	0	0	0	13.99	0	0	11.6	0.1	1.1
2025	4	23	6	5	24	0	0	0	0	0	0	0	14	0	0	11.6	0.1	1.1
2025	4	23	6	15	24	0	0	0	0	0	0	0	14	0	0	11.6	0.1	1.1
2025	4	23	6	25	24	0	0	0	0	0	0	0	14	0	0	11.6	0.1	1.1
2025	4	23	6	35	24	0	0	0	0	0	0	0	14.02	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	23	6	45	24	0	0	0	0	0	0	0	14.02	0	0	11.6	0.1	1.1
2025	4	23	6	55	24	0	0	0	0	0	0	0	14.03	0	0	11.6	0.1	1.1
2025	4	23	7	5	24	0	0	0	0	0	0	0	14.04	0	0	11.6	0.1	1.1
2025	4	23	7	15	24	0	0	0	0	0	0	0	14.05	0	0	11.8	0.1	1.1
2025	4	23	7	25	24	0	0	0	0	0	0	0	14.07	0	0	12	0.1	1.1
2025	4	23	7	35	24	0	0	0	0	0	0	0	14.09	0	0	12.2	0.1	1.1
2025	4	23	7	45	24	0	0	0	0	0	0	0	14.12	0	0	12.4	0.1	1.1
2025	4	23	7	55	24	0	0	0	0	0	0	0	14.16	0	0	12.4	0.1	1.1
2025	4	23	8	5	24	0	0	0	0	0	0	0	14.19	0	0	12.6	0.1	1.1
2025	4	23	8	15	24	0	0	0	0	0	0	0	14.23	0	0	12.6	0.1	1.1
2025	4	23	8	25	24	0	0	0	0	0	0	0	14.27	0	0	12.6	0.1	1.1
2025	4	23	8	35	24	0	0	0	0	0	0	0	14.32	0	0	12.8	0.1	1.1
2025	4	23	8	45	24	0	0	0	0	0	0	0	14.36	0	0	12.8	0.1	1.1
2025	4	23	8	55	24	0	0	0	0	0	0	0	14.41	0	0	12.8	0.1	1.1
2025	4	23	9	5	24	0	0	0	0	0	0	0	14.46	0	0	13	0.1	1.1
2025	4	23	9	15	24	0	0	0	0	0	0	0	14.51	0	0	13.2	0.1	1.1
2025	4	23	9	25	24	0	0	0	0	0	0	0	14.56	0	0	13.4	0.1	1.1
2025	4	23	9	35	24	0	0	0	0	0	0	0	14.61	0	0	13.4	0.1	1.1
2025	4	23	9	45	24	0	0	0	0	0	0	0	14.67	0	0	13.4	0.1	1.1
2025	4	23	9	55	24	0	0	0	0	0	0	0	14.72	0	0	13.4	0.1	1.1
2025	4	23	10	5	24	0	0	0	0	0	0	0	14.78	0	0	13.4	0.1	1.1
2025	4	23	10	15	24	0	0	0	0	0	0	0	14.84	0	0	13.4	0.1	1.1
2025	4	23	10	25	24	0	0	0	0	0	0	0	14.91	0	0	13.4	0.1	1.1
2025	4	23	10	35	24	0	0	0	0	0	0	0	14.96	0	0	13.4	0.1	1.1
2025	4	23	10	45	24	0	0	0	0	0	0	0	15.03	0	0	13.4	0.1	1.1
2025	4	23	10	55	24	0	0	0	0	0	0	0	15.07	0	0	13.2	0.1	1.1
2025	4	23	11	5	24	0	0	0	0	0	0	0	15.15	0	0	13.2	0.1	1.1
2025	4	23	11	15	24	0	0	0	0	0	0	0	15.21	0	0	13.2	0.1	1.1
2025	4	23	11	25	24	0	0	0	0	0	0	0	15.27	0	0	13.2	0.1	1.1
2025	4	23	11	35	24	0	0	0	0	0	0	0	15.34	0	0	13.2	0.1	1.1
2025	4	23	11	45	24	0	0	0	0	0	0	0	15.39	0	0	13.2	0.1	1.1
2025	4	23	11	55	24	0	0	0	0	0	0	0	15.47	0	0	13.2	0.1	1.1
2025	4	23	12	5	24	0	0	0	0	0	0	0	15.53	0	0	13.2	0.1	1.1
2025	4	23	12	15	24	0	0	0	0	0	0	0	15.58	0	0	13.2	0.1	1.1
2025	4	23	12	25	24	0	0	0	0	0	0	0	15.64	0	0	13.2	0.1	1.1
2025	4	23	12	35	24	0	0	0	0	0	0	0	15.7	0	0	13.2	0.1	1.1
2025	4	23	12	45	24	0	0	0	0	0	0	0	15.74	0	0	13.2	0.1	1.1
2025	4	23	12	55	24	0	0	0	0	0	0	0	15.8	0	0	13.2	0.1	1.1
2025	4	23	13	5	24	0	0	0	0	0	0	0	15.84	0	0	13.2	0.1	1.1
2025	4	23	13	15	24	0	0	0	0	0	0	0	15.89	0	0	13.2	0.1	1.1
2025	4	23	13	25	24	0	0	0	0	0	0	0	15.94	0	0	13.2	0.1	1.1
2025	4	23	13	35	24	0	0	0	0	0	0	0	15.97	0	0	13.2	0.1	1.1
2025	4	23	13	45	24	0	0	0	0	0	0	0	16.02	0	0	13.2	0.1	1.1
2025	4	23	13	55	24	0	0	0	0	0	0	0	16.05	0	0	13.2	0.1	1.1
2025	4	23	14	5	24	0	0	0	0	0	0	0	16.08	0	0	13.2	0.1	1.1
2025	4	23	14	15	24	0	0	0	0	0	0	0	16.11	0	0	13.2	0.1	1.1
2025	4	23	14	25	24	0	0	0	0	0	0	0	16.13	0	0	13.2	0.1	1.1
2025	4	23	14	35	24	0	0	0	0	0	0	0	16.16	0	0	13.2	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	23	14	45	24	0	0	0	0	0	0	0	16.19	0	0	13.2	0.1	1.1
2025	4	23	14	55	24	0	0	0	0	0	0	0	16.21	0	0	13.2	0.1	1.1
2025	4	23	15	5	24	0	0	0	0	0	0	0	16.22	0	0	13.2	0.1	1.1
2025	4	23	15	15	24	0	0	0	0	0	0	0	16.24	0	0	13.2	0.1	1.1
2025	4	23	15	25	24	0	0	0	0	0	0	0	16.25	0	0	13.2	0.1	1.1
2025	4	23	15	35	24	0	0	0	0	0	0	0	16.27	0	0	13.2	0.1	1.1
2025	4	23	15	45	24	0	0	0	0	0	0	0	16.27	0	0	13.2	0.1	1.1
2025	4	23	15	55	24	0	0	0	0	0	0	0	16.28	0	0	13.2	0.1	1.1
2025	4	23	16	5	24	0	0	0	0	0	0	0	16.26	0	0	13	0.1	1.1
2025	4	23	16	15	24	0	0	0	0	0	0	0	16.25	0	0	13.4	0.1	1.1
2025	4	23	16	25	24	0	0	0	0	0	0	0	16.22	0	0	12.4	0.1	1.1
2025	4	23	16	35	24	0	0	0	0	0	0	0	16.23	0	0	13.2	0.1	1.1
2025	4	23	16	45	24	0	0	0	0	0	0	0	16.22	0	0	13.2	0.1	1.1
2025	4	23	16	55	24	0	0	0	0	0	0	0	16.2	0	0	13.2	0.1	1.1
2025	4	23	17	5	24	0	0	0	0	0	0	0	16.18	0	0	12.6	0.1	1.1
2025	4	23	17	15	24	0	0	0	0	0	0	0	16.15	0	0	12.4	0.1	1.1
2025	4	23	17	25	24	0	0	0	0	0	0	0	16.14	0	0	12.4	0.1	1.1
2025	4	23	17	35	24	0	0	0	0	0	0	0	16.11	0	0	12.4	0.1	1.1
2025	4	23	17	45	24	0	0	0	0	0	0	0	16.08	0	0	12.2	0.1	1.1
2025	4	23	17	55	24	0	0	0	0	0	0	0	16.04	0	0	12	0.1	1.1
2025	4	23	18	5	24	0	0	0	0	0	0	0	16	0	0	12	0.1	1.1
2025	4	23	18	15	24	0	0	0	0	0	0	0	15.96	0	0	12	0.1	1.1
2025	4	23	18	25	24	0	0	0	0	0	0	0	15.93	0	0	11.8	0.1	1.1
2025	4	23	18	35	24	0	0	0	0	0	0	0	15.9	0	0	11.8	0.1	1.1
2025	4	23	18	45	24	0	0	0	0	0	0	0	15.85	0	0	11.8	0.1	1.1
2025	4	23	18	55	24	0	0	0	0	0	0	0	15.8	0	0	11.8	0.1	1.1
2025	4	23	19	5	24	0	0	0	0	0	0	0	15.75	0	0	11.8	0.1	1.1
2025	4	23	19	15	24	0	0	0	0	0	0	0	15.7	0	0	11.8	0.1	1.1
2025	4	23	19	25	24	0	0	0	0	0	0	0	15.65	0	0	11.8	0.1	1.1
2025	4	23	19	35	24	0	0	0	0	0	0	0	15.59	0	0	11.8	0.1	1.1
2025	4	23	19	45	24	0	0	0	0	0	0	0	15.55	0	0	11.8	0.1	1.1
2025	4	23	19	55	24	0	0	0	0	0	0	0	15.5	0	0	11.8	0.1	1.1
2025	4	23	20	5	24	0	0	0	0	0	0	0	15.45	0	0	11.8	0.1	1.1
2025	4	23	20	15	24	0	0	0	0	0	0	0	15.39	0	0	11.8	0.1	1.1
2025	4	23	20	25	24	0	0	0	0	0	0	0	15.35	0	0	11.8	0.1	1.1
2025	4	23	20	35	24	0	0	0	0	0	0	0	15.3	0	0	11.8	0.1	1.1
2025	4	23	20	45	24	0	0	0	0	0	0	0	15.25	0	0	11.8	0.1	1.1
2025	4	23	20	55	24	0	0	0	0	0	0	0	15.2	0	0	11.8	0.1	1.1
2025	4	23	21	5	24	0	0	0	0	0	0	0	15.16	0	0	11.8	0.1	1.1
2025	4	23	21	15	24	0	0	0	0	0	0	0	15.12	0	0	11.8	0.1	1.1
2025	4	23	21	25	24	0	0	0	0	0	0	0	15.07	0	0	11.8	0.1	1.1
2025	4	23	21	35	24	0	0	0	0	0	0	0	15.03	0	0	11.8	0.1	1.1
2025	4	23	21	45	24	0	0	0	0	0	0	0	14.99	0	0	11.8	0.1	1.1
2025	4	23	21	55	24	0	0	0	0	0	0	0	14.96	0	0	11.8	0.1	1.1
2025	4	23	22	5	24	0	0	0	0	0	0	0	14.92	0	0	11.8	0.1	1.1
2025	4	23	22	15	24	0	0	0	0	0	0	0	14.88	0	0	11.8	0.1	1.1
2025	4	23	22	25	24	0	0	0	0	0	0	0	14.85	0	0	11.8	0.1	1.1
2025	4	23	22	35	24	0	0	0	0	0	0	0	14.81	0	0	11.8	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	23	22	45	24	0	0	0	0	0	0	0	14.78	0	0	11.8	0.1	1.1
2025	4	23	22	55	24	0	0	0	0	0	0	0	14.75	0	0	11.8	0.1	1.1
2025	4	23	23	5	24	0	0	0	0	0	0	0	14.72	0	0	11.8	0.1	1.1
2025	4	23	23	15	24	0	0	0	0	0	0	0	14.69	0	0	11.8	0.1	1.1
2025	4	23	23	25	24	0	0	0	0	0	0	0	14.67	0	0	11.8	0.1	1.1
2025	4	23	23	35	24	0	0	0	0	0	0	0	14.64	0	0	11.8	0.1	1.1
2025	4	23	23	45	24	0	0	0	0	0	0	0	14.62	0	0	11.6	0.1	1.1
2025	4	23	23	55	24	0	0	0	0	0	0	0	14.6	0	0	11.6	0.1	1.1
2025	4	24	0	5	24	0	0	0	0	0	0	0	14.59	0	0	11.6	0.1	1.1
2025	4	24	0	15	24	0	0	0	0	0	0	0	14.57	0	0	11.6	0.1	1.1
2025	4	24	0	25	24	0	0	0	0	0	0	0	14.55	0	0	11.6	0.1	1.1
2025	4	24	0	35	24	0	0	0	0	0	0	0	14.53	0	0	11.6	0.1	1.1
2025	4	24	0	45	24	0	0	0	0	0	0	0	14.53	0	0	11.6	0.1	1.1
2025	4	24	0	55	24	0	0	0	0	0	0	0	14.51	0	0	11.6	0.1	1.1
2025	4	24	1	5	24	0	0	0	0	0	0	0	14.5	0	0	11.6	0.1	1.1
2025	4	24	1	15	24	0	0	0	0	0	0	0	14.5	0	0	11.6	0.1	1.1
2025	4	24	1	25	24	0	0	0	0	0	0	0	14.49	0	0	11.6	0.1	1.1
2025	4	24	1	35	24	0	0	0	0	0	0	0	14.48	0	0	11.6	0.1	1.1
2025	4	24	1	45	24	0	0	0	0	0	0	0	14.47	0	0	11.6	0.1	1.1
2025	4	24	1	55	24	0	0	0	0	0	0	0	14.47	0	0	11.6	0.1	1.1
2025	4	24	2	5	24	0	0	0	0	0	0	0	14.47	0	0	11.6	0.1	1.1
2025	4	24	2	15	24	0	0	0	0	0	0	0	14.47	0	0	11.6	0.1	1.1
2025	4	24	2	25	24	0	0	0	0	0	0	0	14.47	0	0	11.6	0.1	1.1
2025	4	24	2	35	24	0	0	0	0	0	0	0	14.47	0	0	11.6	0.1	1.1
2025	4	24	2	45	24	0	0	0	0	0	0	0	14.47	0	0	11.6	0.1	1.1
2025	4	24	2	55	24	0	0	0	0	0	0	0	14.48	0	0	11.6	0.1	1.1
2025	4	24	3	5	24	0	0	0	0	0	0	0	14.48	0	0	11.6	0.1	1.1
2025	4	24	3	15	24	0	0	0	0	0	0	0	14.48	0	0	11.6	0.1	1.1
2025	4	24	3	25	24	0	0	0	0	0	0	0	14.49	0	0	11.6	0.1	1.1
2025	4	24	3	35	24	0	0	0	0	0	0	0	14.49	0	0	11.6	0.1	1.1
2025	4	24	3	45	24	0	0	0	0	0	0	0	14.5	0	0	11.6	0.1	1.1
2025	4	24	3	55	24	0	0	0	0	0	0	0	14.51	0	0	11.6	0.1	1.1
2025	4	24	4	5	24	0	0	0	0	0	0	0	14.52	0	0	11.6	0.1	1.1
2025	4	24	4	15	24	0	0	0	0	0	0	0	14.53	0	0	11.6	0.1	1.1
2025	4	24	4	25	24	0	0	0	0	0	0	0	14.54	0	0	11.6	0.1	1.1
2025	4	24	4	35	24	0	0	0	0	0	0	0	14.55	0	0	11.6	0.1	1.1
2025	4	24	4	45	24	0	0	0	0	0	0	0	14.56	0	0	11.6	0.1	1.1
2025	4	24	4	55	24	0	0	0	0	0	0	0	14.56	0	0	11.6	0.1	1.1
2025	4	24	5	5	24	0	0	0	0	0	0	0	14.57	0	0	11.6	0.1	1.1
2025	4	24	5	15	24	0	0	0	0	0	0	0	14.58	0	0	11.6	0.1	1.1
2025	4	24	5	25	24	0	0	0	0	0	0	0	14.59	0	0	11.6	0.1	1.1
2025	4	24	5	35	24	0	0	0	0	0	0	0	14.59	0	0	11.6	0.1	1.1
2025	4	24	5	45	24	0	0	0	0	0	0	0	14.59	0	0	11.6	0.1	1.1
2025	4	24	5	55	24	0	0	0	0	0	0	0	14.61	0	0	11.6	0.1	1.1
2025	4	24	6	5	24	0	0	0	0	0	0	0	14.61	0	0	11.6	0.1	1.1
2025	4	24	6	15	24	0	0	0	0	0	0	0	14.62	0	0	11.6	0.1	1.1
2025	4	24	6	25	24	0	0	0	0	0	0	0	14.63	0	0	11.6	0.1	1.1
2025	4	24	6	35	24	0	0	0	0	0	0	0	14.64	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	24	6	45	24	0	0	0	0	0	0	0	14.65	0	0	11.6	0.1	1.1
2025	4	24	6	55	24	0	0	0	0	0	0	0	14.66	0	0	11.6	0.1	1.1
2025	4	24	7	5	24	0	0	0	0	0	0	0	14.68	0	0	11.6	0.1	1.1
2025	4	24	7	15	24	0	0	0	0	0	0	0	14.69	0	0	11.8	0.1	1.1
2025	4	24	7	25	24	0	0	0	0	0	0	0	14.7	0	0	11.8	0.1	1.1
2025	4	24	7	35	24	0	0	0	0	0	0	0	14.71	0	0	12	0.1	1.1
2025	4	24	7	45	24	0	0	0	0	0	0	0	14.73	0	0	12	0.1	1.1
2025	4	24	7	55	24	0	0	0	0	0	0	0	14.74	0	0	12.2	0.1	1.1
2025	4	24	8	5	24	0	0	0	0	0	0	0	14.76	0	0	12.4	0.1	1.1
2025	4	24	8	15	24	0	0	0	0	0	0	0	14.78	0	0	12.6	0.1	1.1
2025	4	24	8	25	24	0	0	0	0	0	0	0	14.81	0	0	12.6	0.1	1.1
2025	4	24	8	35	24	0	0	0	0	0	0	0	14.84	0	0	12.6	0.1	1.1
2025	4	24	8	45	24	0	0	0	0	0	0	0	14.86	0	0	12.6	0.1	1.1
2025	4	24	8	55	24	0	0	0	0	0	0	0	14.9	0	0	12.8	0.1	1.1
2025	4	24	9	5	24	0	0	0	0	0	0	0	14.93	0	0	12.8	0.1	1.1
2025	4	24	9	15	24	0	0	0	0	0	0	0	14.96	0	0	13	0.1	1.1
2025	4	24	9	25	24	0	0	0	0	0	0	0	15.01	0	0	13	0.1	1.1
2025	4	24	9	35	24	0	0	0	0	0	0	0	15.05	0	0	13.4	0.1	1.1
2025	4	24	9	45	24	0	0	0	0	0	0	0	15.08	0	0	13.6	0.1	1.1
2025	4	24	9	55	24	0	0	0	0	0	0	0	15.12	0	0	13.6	0.1	1.1
2025	4	24	10	5	24	0	0	0	0	0	0	0	15.18	0	0	13.6	0.1	1.1
2025	4	24	10	15	24	0	0	0	0	0	0	0	15.22	0	0	13.4	0.1	1.1
2025	4	24	10	25	24	0	0	0	0	0	0	0	15.26	0	0	13.4	0.1	1.1
2025	4	24	10	35	24	0	0	0	0	0	0	0	15.31	0	0	13.4	0.1	1.1
2025	4	24	10	45	24	0	0	0	0	0	0	0	15.37	0	0	13.4	0.1	1.1
2025	4	24	10	55	24	0	0	0	0	0	0	0	15.41	0	0	13.4	0.1	1.1
2025	4	24	11	5	24	0	0	0	0	0	0	0	15.47	0	0	13.4	0.1	1.1
2025	4	24	11	15	24	0	0	0	0	0	0	0	15.52	0	0	13.4	0.1	1.1
2025	4	24	11	25	24	0	0	0	0	0	0	0	15.57	0	0	13.4	0.1	1.1
2025	4	24	11	35	24	0	0	0	0	0	0	0	15.63	0	0	13.4	0.1	1.1
2025	4	24	11	45	24	0	0	0	0	0	0	0	15.67	0	0	13.4	0.1	1.1
2025	4	24	11	55	24	0	0	0	0	0	0	0	15.71	0	0	13.4	0.1	1.1
2025	4	24	12	5	24	0	0	0	0	0	0	0	15.78	0	0	13.4	0.1	1.1
2025	4	24	12	15	24	0	0	0	0	0	0	0	15.82	0	0	13.4	0.1	1.1
2025	4	24	12	25	24	0	0	0	0	0	0	0	15.85	0	0	13.4	0.1	1.1
2025	4	24	12	35	24	0	0	0	0	0	0	0	15.9	0	0	13.4	0.1	1.1
2025	4	24	12	45	24	0	0	0	0	0	0	0	15.95	0	0	13.2	0.1	1.1
2025	4	24	12	55	24	0	0	0	0	0	0	0	15.98	0	0	13.2	0.1	1.1
2025	4	24	13	5	24	0	0	0	0	0	0	0	16.02	0	0	13.4	0.1	1.1
2025	4	24	13	15	24	0	0	0	0	0	0	0	16.06	0	0	13.4	0.1	1.1
2025	4	24	13	25	24	0	0	0	0	0	0	0	16.08	0	0	13.4	0.1	1.1
2025	4	24	13	35	24	0	0	0	0	0	0	0	16.1	0	0	13.4	0.1	1.1
2025	4	24	13	45	24	0	0	0	0	0	0	0	16.12	0	0	13.4	0.1	1.1
2025	4	24	13	55	24	0	0	0	0	0	0	0	16.16	0	0	13.4	0.1	1.1
2025	4	24	14	5	24	0	0	0	0	0	0	0	16.19	0	0	13.4	0.1	1.1
2025	4	24	14	15	24	0	0	0	0	0	0	0	16.19	0	0	13.4	0.1	1.1
2025	4	24	14	25	24	0	0	0	0	0	0	0	16.22	0	0	13.4	0.1	1.1
2025	4	24	14	35	24	0	0	0	0	0	0	0	16.23	0	0	13.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	24	14	45	24	0	0	0	0	0	0	0	16.24	0	0	13.4	0.1	1.1
2025	4	24	14	55	24	0	0	0	0	0	0	0	16.26	0	0	13.4	0.1	1.1
2025	4	24	15	5	24	0	0	0	0	0	0	0	16.28	0	0	13.4	0.1	1.1
2025	4	24	15	15	24	0	0	0	0	0	0	0	16.29	0	0	13.4	0.1	1.1
2025	4	24	15	25	24	0	0	0	0	0	0	0	16.3	0	0	13.4	0.1	1.1
2025	4	24	15	35	24	0	0	0	0	0	0	0	16.28	0	0	13.4	0.1	1.1
2025	4	24	15	45	24	0	0	0	0	0	0	0	16.28	0	0	13.4	0.1	1.1
2025	4	24	15	55	24	0	0	0	0	0	0	0	16.26	0	0	13.4	0.1	1.1
2025	4	24	16	5	24	0	0	0	0	0	0	0	16.25	0	0	13.4	0.1	1.1
2025	4	24	16	15	24	0	0	0	0	0	0	0	16.24	0	0	13.4	0.1	1.1
2025	4	24	16	25	24	0	0	0	0	0	0	0	16.23	0	0	13.4	0.1	1.1
2025	4	24	16	35	24	0	0	0	0	0	0	0	16.22	0	0	13.4	0.1	1.1
2025	4	24	16	45	24	0	0	0	0	0	0	0	16.2	0	0	13.4	0.1	1.1
2025	4	24	16	55	24	0	0	0	0	0	0	0	16.18	0	0	13	0.1	1.1
2025	4	24	17	5	24	0	0	0	0	0	0	0	16.16	0	0	12.8	0.1	1.1
2025	4	24	17	15	24	0	0	0	0	0	0	0	16.13	0	0	12.6	0.1	1.1
2025	4	24	17	25	24	0	0	0	0	0	0	0	16.1	0	0	12.6	0.1	1.1
2025	4	24	17	35	24	0	0	0	0	0	0	0	16.07	0	0	12.4	0.1	1.1
2025	4	24	17	45	24	0	0	0	0	0	0	0	16.03	0	0	12.4	0.1	1.1
2025	4	24	17	55	24	0	0	0	0	0	0	0	15.99	0	0	12.2	0.1	1.1
2025	4	24	18	5	24	0	0	0	0	0	0	0	15.95	0	0	12.2	0.1	1.1
2025	4	24	18	15	24	0	0	0	0	0	0	0	15.9	0	0	12	0.1	1.1
2025	4	24	18	25	24	0	0	0	0	0	0	0	15.86	0	0	12	0.1	1.1
2025	4	24	18	35	24	0	0	0	0	0	0	0	15.82	0	0	12	0.1	1.1
2025	4	24	18	45	24	0	0	0	0	0	0	0	15.77	0	0	11.8	0.1	1.1
2025	4	24	18	55	24	0	0	0	0	0	0	0	15.72	0	0	11.8	0.1	1.1
2025	4	24	19	5	24	0	0	0	0	0	0	0	15.67	0	0	11.8	0.1	1.1
2025	4	24	19	15	24	0	0	0	0	0	0	0	15.62	0	0	11.8	0.1	1.1
2025	4	24	19	25	24	0	0	0	0	0	0	0	15.57	0	0	11.8	0.1	1.1
2025	4	24	19	35	24	0	0	0	0	0	0	0	15.51	0	0	11.8	0.1	1.1
2025	4	24	19	45	24	0	0	0	0	0	0	0	15.46	0	0	11.8	0.1	1.1
2025	4	24	19	55	24	0	0	0	0	0	0	0	15.4	0	0	11.8	0.1	1.1
2025	4	24	20	5	24	0	0	0	0	0	0	0	15.35	0	0	11.8	0.1	1.1
2025	4	24	20	15	24	0	0	0	0	0	0	0	15.29	0	0	11.8	0.1	1.1
2025	4	24	20	25	24	0	0	0	0	0	0	0	15.24	0	0	11.8	0.1	1.1
2025	4	24	20	35	24	0	0	0	0	0	0	0	15.18	0	0	11.8	0.1	1.1
2025	4	24	20	45	24	0	0	0	0	0	0	0	15.13	0	0	11.8	0.1	1.1
2025	4	24	20	55	24	0	0	0	0	0	0	0	15.09	0	0	11.8	0.1	1.1
2025	4	24	21	5	24	0	0	0	0	0	0	0	15.04	0	0	11.8	0.1	1.1
2025	4	24	21	15	24	0	0	0	0	0	0	0	14.99	0	0	11.8	0.1	1.1
2025	4	24	21	25	24	0	0	0	0	0	0	0	14.94	0	0	11.8	0.1	1.1
2025	4	24	21	35	24	0	0	0	0	0	0	0	14.9	0	0	11.8	0.1	1.1
2025	4	24	21	45	24	0	0	0	0	0	0	0	14.86	0	0	11.8	0.1	1.1
2025	4	24	21	55	24	0	0	0	0	0	0	0	14.83	0	0	11.8	0.1	1.1
2025	4	24	22	5	24	0	0	0	0	0	0	0	14.79	0	0	11.8	0.1	1.1
2025	4	24	22	15	24	0	0	0	0	0	0	0	14.75	0	0	11.8	0.1	1.1
2025	4	24	22	25	24	0	0	0	0	0	0	0	14.71	0	0	11.8	0.1	1.1
2025	4	24	22	35	24	0	0	0	0	0	0	0	14.68	0	0	11.8	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	24	22	45	24	0	0	0	0	0	0	0	14.65	0	0	11.8	0.1	1.1
2025	4	24	22	55	24	0	0	0	0	0	0	0	14.61	0	0	11.8	0.1	1.1
2025	4	24	23	5	24	0	0	0	0	0	0	0	14.57	0	0	11.8	0.1	1.1
2025	4	24	23	15	24	0	0	0	0	0	0	0	14.54	0	0	11.8	0.1	1.1
2025	4	24	23	25	24	0	0	0	0	0	0	0	14.52	0	0	11.8	0.1	1.1
2025	4	24	23	35	24	0	0	0	0	0	0	0	14.49	0	0	11.8	0.1	1.1
2025	4	24	23	45	24	0	0	0	0	0	0	0	14.47	0	0	11.8	0.1	1.1
2025	4	24	23	55	24	0	0	0	0	0	0	0	14.45	0	0	11.8	0.1	1.1
2025	4	25	0	5	24	0	0	0	0	0	0	0	14.44	0	0	11.8	0.1	1.1
2025	4	25	0	15	24	0	0	0	0	0	0	0	14.42	0	0	11.6	0.1	1.1
2025	4	25	0	25	24	0	0	0	0	0	0	0	14.42	0	0	11.6	0.1	1.1
2025	4	25	0	35	24	0	0	0	0	0	0	0	14.4	0	0	11.6	0.1	1.1
2025	4	25	0	45	24	0	0	0	0	0	0	0	14.39	0	0	11.6	0.1	1.1
2025	4	25	0	55	24	0	0	0	0	0	0	0	14.38	0	0	11.6	0.1	1.1
2025	4	25	1	5	24	0	0	0	0	0	0	0	14.37	0	0	11.6	0.1	1.1
2025	4	25	1	15	24	0	0	0	0	0	0	0	14.36	0	0	11.6	0.1	1.1
2025	4	25	1	25	24	0	0	0	0	0	0	0	14.35	0	0	11.6	0.1	1.1
2025	4	25	1	35	24	0	0	0	0	0	0	0	14.35	0	0	11.6	0.1	1.1
2025	4	25	1	45	24	0	0	0	0	0	0	0	14.35	0	0	11.6	0.1	1.1
2025	4	25	1	55	24	0	0	0	0	0	0	0	14.34	0	0	11.6	0.1	1.1
2025	4	25	2	5	24	0	0	0	0	0	0	0	14.34	0	0	11.6	0.1	1.1
2025	4	25	2	15	24	0	0	0	0	0	0	0	14.34	0	0	11.6	0.1	1.1
2025	4	25	2	25	24	0	0	0	0	0	0	0	14.34	0	0	11.6	0.1	1.1
2025	4	25	2	35	24	0	0	0	0	0	0	0	14.34	0	0	11.6	0.1	1.1
2025	4	25	2	45	24	0	0	0	0	0	0	0	14.34	0	0	11.6	0.1	1.1
2025	4	25	2	55	24	0	0	0	0	0	0	0	14.35	0	0	11.6	0.1	1.1
2025	4	25	3	5	24	0	0	0	0	0	0	0	14.35	0	0	11.6	0.1	1.1
2025	4	25	3	15	24	0	0	0	0	0	0	0	14.37	0	0	11.6	0.1	1.1
2025	4	25	3	25	24	0	0	0	0	0	0	0	14.38	0	0	11.6	0.1	1.1
2025	4	25	3	35	24	0	0	0	0	0	0	0	14.38	0	0	11.6	0.1	1.1
2025	4	25	3	45	24	0	0	0	0	0	0	0	14.39	0	0	11.6	0.1	1.1
2025	4	25	3	55	24	0	0	0	0	0	0	0	14.4	0	0	11.6	0.1	1.1
2025	4	25	4	5	24	0	0	0	0	0	0	0	14.41	0	0	11.6	0.1	1.1
2025	4	25	4	15	24	0	0	0	0	0	0	0	14.41	0	0	11.6	0.1	1.1
2025	4	25	4	25	24	0	0	0	0	0	0	0	14.42	0	0	11.6	0.1	1.1
2025	4	25	4	35	24	0	0	0	0	0	0	0	14.42	0	0	11.6	0.1	1.1
2025	4	25	4	45	24	0	0	0	0	0	0	0	14.44	0	0	11.6	0.1	1.1
2025	4	25	4	55	24	0	0	0	0	0	0	0	14.45	0	0	11.6	0.1	1.1
2025	4	25	5	5	24	0	0	0	0	0	0	0	14.46	0	0	11.6	0.1	1.1
2025	4	25	5	15	24	0	0	0	0	0	0	0	14.48	0	0	11.6	0.1	1.1
2025	4	25	5	25	24	0	0	0	0	0	0	0	14.48	0	0	11.6	0.1	1.1
2025	4	25	5	35	24	0	0	0	0	0	0	0	14.49	0	0	11.6	0.1	1.1
2025	4	25	5	45	24	0	0	0	0	0	0	0	14.5	0	0	11.6	0.1	1.1
2025	4	25	5	55	24	0	0	0	0	0	0	0	14.51	0	0	11.6	0.1	1.1
2025	4	25	6	5	24	0	0	0	0	0	0	0	14.52	0	0	11.6	0.1	1.1
2025	4	25	6	15	24	0	0	0	0	0	0	0	14.53	0	0	11.6	0.1	1.1
2025	4	25	6	25	24	0	0	0	0	0	0	0	14.55	0	0	11.6	0.1	1.1
2025	4	25	6	35	24	0	0	0	0	0	0	0	14.56	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	25	6	45	24	0	0	0	0	0	0	0	14.57	0	0	11.6	0.1	1.1
2025	4	25	6	55	24	0	0	0	0	0	0	0	14.58	0	0	11.6	0.1	1.1
2025	4	25	7	5	24	0	0	0	0	0	0	0	14.59	0	0	11.8	0.1	1.1
2025	4	25	7	15	24	0	0	0	0	0	0	0	14.6	0	0	11.8	0.1	1.1
2025	4	25	7	25	24	0	0	0	0	0	0	0	14.62	0	0	12	0.1	1.1
2025	4	25	7	35	24	0	0	0	0	0	0	0	14.65	0	0	12.4	0.1	1.1
2025	4	25	7	45	24	0	0	0	0	0	0	0	14.67	0	0	12.6	0.1	1.1
2025	4	25	7	55	24	0	0	0	0	0	0	0	14.7	0	0	12.6	0.1	1.1
2025	4	25	8	5	24	0	0	0	0	0	0	0	14.7	0	0	12.2	0.1	1.1
2025	4	25	8	15	24	0	0	0	0	0	0	0	14.7	0	0	12	0.1	1.1
2025	4	25	8	25	24	0	0	0	0	0	0	0	14.71	0	0	12.2	0.1	1.1
2025	4	25	8	35	24	0	0	0	0	0	0	0	14.73	0	0	12.4	0.1	1.1
2025	4	25	8	45	24	0	0	0	0	0	0	0	14.77	0	0	13.4	0.1	1.1
2025	4	25	8	55	24	0	0	0	0	0	0	0	14.8	0	0	13.2	0.1	1.1
2025	4	25	9	5	24	0	0	0	0	0	0	0	14.83	0	0	13.2	0.1	1.1
2025	4	25	9	15	24	0	0	0	0	0	0	0	14.86	0	0	13.2	0.1	1.1
2025	4	25	9	25	24	0	0	0	0	0	0	0	14.9	0	0	13.4	0.1	1.1
2025	4	25	9	35	24	0	0	0	0	0	0	0	14.94	0	0	13.6	0.1	1.1
2025	4	25	9	45	24	0	0	0	0	0	0	0	14.97	0	0	13.6	0.1	1.1
2025	4	25	9	55	24	0	0	0	0	0	0	0	15.01	0	0	13.6	0.1	1.1
2025	4	25	10	5	24	0	0	0	0	0	0	0	15.05	0	0	13.6	0.1	1.1
2025	4	25	10	15	24	0	0	0	0	0	0	0	15.08	0	0	13.6	0.1	1.1
2025	4	25	10	25	24	0	0	0	0	0	0	0	15.12	0	0	13.6	0.1	1.1
2025	4	25	10	35	24	0	0	0	0	0	0	0	15.17	0	0	13.6	0.1	1.1
2025	4	25	10	45	24	0	0	0	0	0	0	0	15.2	0	0	13.6	0.1	1.1
2025	4	25	10	55	24	0	0	0	0	0	0	0	15.24	0	0	13.6	0.1	1.1
2025	4	25	11	5	24	0	0	0	0	0	0	0	15.28	0	0	13.6	0.1	1.1
2025	4	25	11	15	24	0	0	0	0	0	0	0	15.32	0	0	13.6	0.1	1.1
2025	4	25	11	25	24	0	0	0	0	0	0	0	15.36	0	0	13.6	0.1	1.1
2025	4	25	11	35	24	0	0	0	0	0	0	0	15.39	0	0	13.6	0.1	1.1
2025	4	25	11	45	24	0	0	0	0	0	0	0	15.44	0	0	13.6	0.1	1.1
2025	4	25	11	55	24	0	0	0	0	0	0	0	15.48	0	0	13.6	0.1	1.1
2025	4	25	12	5	24	0	0	0	0	0	0	0	15.51	0	0	13.6	0.1	1.1
2025	4	25	12	15	24	0	0	0	0	0	0	0	15.55	0	0	13.6	0.1	1.1
2025	4	25	12	25	24	0	0	0	0	0	0	0	15.59	0	0	13.6	0.1	1.1
2025	4	25	12	35	24	0	0	0	0	0	0	0	15.62	0	0	13.6	0.1	1.1
2025	4	25	12	45	24	0	0	0	0	0	0	0	15.65	0	0	13.6	0.1	1.1
2025	4	25	12	55	24	0	0	0	0	0	0	0	15.68	0	0	13.6	0.1	1.1
2025	4	25	13	5	24	0	0	0	0	0	0	0	15.72	0	0	13.6	0.1	1.1
2025	4	25	13	15	24	0	0	0	0	0	0	0	15.75	0	0	13.6	0.1	1.1
2025	4	25	13	25	24	0	0	0	0	0	0	0	15.77	0	0	13.6	0.1	1.1
2025	4	25	13	35	24	0	0	0	0	0	0	0	15.8	0	0	13.6	0.1	1.1
2025	4	25	13	45	24	0	0	0	0	0	0	0	15.82	0	0	13.6	0.1	1.1
2025	4	25	13	55	24	0	0	0	0	0	0	0	15.84	0	0	13.6	0.1	1.1
2025	4	25	14	5	24	0	0	0	0	0	0	0	15.85	0	0	13.6	0.1	1.1
2025	4	25	14	15	24	0	0	0	0	0	0	0	15.87	0	0	13.4	0.1	1.1
2025	4	25	14	25	24	0	0	0	0	0	0	0	15.88	0	0	13.6	0.1	1.1
2025	4	25	14	35	24	0	0	0	0	0	0	0	15.88	0	0	13.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	25	14	45	24	0	0	0	0	0	0	0	15.89	0	0	13.8	0.1	1.1
2025	4	25	14	55	24	0	0	0	0	0	0	0	15.89	0	0	13.8	0.1	1.1
2025	4	25	15	5	24	0	0	0	0	0	0	0	15.88	0	0	13.8	0.1	1.1
2025	4	25	15	15	24	0	0	0	0	0	0	0	15.88	0	0	13.8	0.1	1.1
2025	4	25	15	25	24	0	0	0	0	0	0	0	15.87	0	0	13.6	0.1	1.1
2025	4	25	15	35	24	0	0	0	0	0	0	0	15.87	0	0	13.8	0.1	1.1
2025	4	25	15	45	24	0	0	0	0	0	0	0	15.86	0	0	13.4	0.1	1.1
2025	4	25	15	55	24	0	0	0	0	0	0	0	15.81	0	0	13.4	0.1	1.1
2025	4	25	16	5	24	0	0	0	0	0	0	0	15.76	0	0	12.8	0.1	1.1
2025	4	25	16	15	24	0	0	0	0	0	0	0	15.75	0	0	13.8	0.1	1.1
2025	4	25	16	25	24	0	0	0	0	0	0	0	15.75	0	0	13.6	0.1	1.1
2025	4	25	16	35	24	0	0	0	0	0	0	0	15.74	0	0	13.6	0.1	1.1
2025	4	25	16	45	24	0	0	0	0	0	0	0	15.72	0	0	13.6	0.1	1.1
2025	4	25	16	55	24	0	0	0	0	0	0	0	15.7	0	0	13.6	0.1	1.1
2025	4	25	17	5	24	0	0	0	0	0	0	0	15.68	0	0	12.8	0.1	1.1
2025	4	25	17	15	24	0	0	0	0	0	0	0	15.64	0	0	12.4	0.1	1.1
2025	4	25	17	25	24	0	0	0	0	0	0	0	15.59	0	0	12.4	0.1	1.1
2025	4	25	17	35	24	0	0	0	0	0	0	0	15.55	0	0	12.2	0.1	1.1
2025	4	25	17	45	24	0	0	0	0	0	0	0	15.51	0	0	12.2	0.1	1.1
2025	4	25	17	55	24	0	0	0	0	0	0	0	15.47	0	0	12	0.1	1.1
2025	4	25	18	5	24	0	0	0	0	0	0	0	15.44	0	0	12	0.1	1.1
2025	4	25	18	15	24	0	0	0	0	0	0	0	15.41	0	0	11.8	0.1	1.1
2025	4	25	18	25	24	0	0	0	0	0	0	0	15.36	0	0	11.8	0.1	1.1
2025	4	25	18	35	24	0	0	0	0	0	0	0	15.32	0	0	11.8	0.1	1.1
2025	4	25	18	45	24	0	0	0	0	0	0	0	15.27	0	0	11.8	0.1	1.1
2025	4	25	18	55	24	0	0	0	0	0	0	0	15.22	0	0	11.8	0.1	1.1
2025	4	25	19	5	24	0	0	0	0	0	0	0	15.17	0	0	11.8	0.1	1.1
2025	4	25	19	15	24	0	0	0	0	0	0	0	15.11	0	0	11.8	0.1	1.1
2025	4	25	19	25	24	0	0	0	0	0	0	0	15.07	0	0	11.8	0.1	1.1
2025	4	25	19	35	24	0	0	0	0	0	0	0	15.01	0	0	11.8	0.1	1.1
2025	4	25	19	45	24	0	0	0	0	0	0	0	14.96	0	0	11.8	0.1	1.1
2025	4	25	19	55	24	0	0	0	0	0	0	0	14.91	0	0	11.8	0.1	1.1
2025	4	25	20	5	24	0	0	0	0	0	0	0	14.86	0	0	11.8	0.1	1.1
2025	4	25	20	15	24	0	0	0	0	0	0	0	14.8	0	0	11.8	0.1	1.1
2025	4	25	20	25	24	0	0	0	0	0	0	0	14.75	0	0	11.8	0.1	1.1
2025	4	25	20	35	24	0	0	0	0	0	0	0	14.7	0	0	11.8	0.1	1.1
2025	4	25	20	45	24	0	0	0	0	0	0	0	14.65	0	0	11.8	0.1	1.1
2025	4	25	20	55	24	0	0	0	0	0	0	0	14.6	0	0	11.8	0.1	1.1
2025	4	25	21	5	24	0	0	0	0	0	0	0	14.55	0	0	11.8	0.1	1.1
2025	4	25	21	15	24	0	0	0	0	0	0	0	14.5	0	0	11.8	0.1	1.1
2025	4	25	21	25	24	0	0	0	0	0	0	0	14.45	0	0	11.8	0.1	1.1
2025	4	25	21	35	24	0	0	0	0	0	0	0	14.4	0	0	11.8	0.1	1.1
2025	4	25	21	45	24	0	0	0	0	0	0	0	14.36	0	0	11.8	0.1	1.1
2025	4	25	21	55	24	0	0	0	0	0	0	0	14.32	0	0	11.8	0.1	1.1
2025	4	25	22	5	24	0	0	0	0	0	0	0	14.28	0	0	11.8	0.1	1.1
2025	4	25	22	15	24	0	0	0	0	0	0	0	14.23	0	0	11.8	0.1	1.1
2025	4	25	22	25	24	0	0	0	0	0	0	0	14.19	0	0	11.8	0.1	1.1
2025	4	25	22	35	24	0	0	0	0	0	0	0	14.15	0	0	11.8	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	25	22	45	24	0	0	0	0	0	0	0	14.11	0	0	11.8	0.1	1.1
2025	4	25	22	55	24	0	0	0	0	0	0	0	14.08	0	0	11.6	0.1	1.1
2025	4	25	23	5	24	0	0	0	0	0	0	0	14.04	0	0	11.6	0.1	1.1
2025	4	25	23	15	24	0	0	0	0	0	0	0	14.01	0	0	11.6	0.1	1.1
2025	4	25	23	25	24	0	0	0	0	0	0	0	13.99	0	0	11.6	0.1	1.1
2025	4	25	23	35	24	0	0	0	0	0	0	0	13.96	0	0	11.6	0.1	1.1
2025	4	25	23	45	24	0	0	0	0	0	0	0	13.93	0	0	11.6	0.1	1.1
2025	4	25	23	55	24	0	0	0	0	0	0	0	13.91	0	0	11.6	0.1	1.1
2025	4	26	0	5	24	0	0	0	0	0	0	0	13.87	0	0	11.6	0.1	1.1
2025	4	26	0	15	24	0	0	0	0	0	0	0	13.86	0	0	11.6	0.1	1.1
2025	4	26	0	25	24	0	0	0	0	0	0	0	13.85	0	0	11.6	0.1	1.1
2025	4	26	0	35	24	0	0	0	0	0	0	0	13.83	0	0	11.6	0.1	1.1
2025	4	26	0	45	24	0	0	0	0	0	0	0	13.82	0	0	11.6	0.1	1.1
2025	4	26	0	55	24	0	0	0	0	0	0	0	13.82	0	0	11.6	0.1	1.1
2025	4	26	1	5	24	0	0	0	0	0	0	0	13.8	0	0	11.6	0.1	1.1
2025	4	26	1	15	24	0	0	0	0	0	0	0	13.8	0	0	11.6	0.1	1.1
2025	4	26	1	25	24	0	0	0	0	0	0	0	13.79	0	0	11.6	0.1	1.1
2025	4	26	1	35	24	0	0	0	0	0	0	0	13.78	0	0	11.6	0.1	1.1
2025	4	26	1	45	24	0	0	0	0	0	0	0	13.77	0	0	11.6	0.1	1.1
2025	4	26	1	55	24	0	0	0	0	0	0	0	13.77	0	0	11.6	0.1	1.1
2025	4	26	2	5	24	0	0	0	0	0	0	0	13.76	0	0	11.6	0.1	1.1
2025	4	26	2	15	24	0	0	0	0	0	0	0	13.76	0	0	11.6	0.1	1.1
2025	4	26	2	25	24	0	0	0	0	0	0	0	13.76	0	0	11.6	0.1	1.1
2025	4	26	2	35	24	0	0	0	0	0	0	0	13.77	0	0	11.6	0.1	1.1
2025	4	26	2	45	24	0	0	0	0	0	0	0	13.76	0	0	11.6	0.1	1.1
2025	4	26	2	55	24	0	0	0	0	0	0	0	13.76	0	0	11.6	0.1	1.1
2025	4	26	3	5	24	0	0	0	0	0	0	0	13.77	0	0	11.6	0.1	1.1
2025	4	26	3	15	24	0	0	0	0	0	0	0	13.77	0	0	11.6	0.1	1.1
2025	4	26	3	25	24	0	0	0	0	0	0	0	13.77	0	0	11.6	0.1	1.1
2025	4	26	3	35	24	0	0	0	0	0	0	0	13.78	0	0	11.6	0.1	1.1
2025	4	26	3	45	24	0	0	0	0	0	0	0	13.78	0	0	11.6	0.1	1.1
2025	4	26	3	55	24	0	0	0	0	0	0	0	13.79	0	0	11.6	0.1	1.1
2025	4	26	4	5	24	0	0	0	0	0	0	0	13.79	0	0	11.6	0.1	1.1
2025	4	26	4	15	24	0	0	0	0	0	0	0	13.8	0	0	11.6	0.1	1.1
2025	4	26	4	25	24	0	0	0	0	0	0	0	13.8	0	0	11.6	0.1	1.1
2025	4	26	4	35	24	0	0	0	0	0	0	0	13.81	0	0	11.6	0.1	1.1
2025	4	26	4	45	24	0	0	0	0	0	0	0	13.82	0	0	11.6	0.1	1.1
2025	4	26	4	55	24	0	0	0	0	0	0	0	13.83	0	0	11.6	0.1	1.1
2025	4	26	5	5	24	0	0	0	0	0	0	0	13.83	0	0	11.6	0.1	1.1
2025	4	26	5	15	24	0	0	0	0	0	0	0	13.84	0	0	11.6	0.1	1.1
2025	4	26	5	25	24	0	0	0	0	0	0	0	13.84	0	0	11.6	0.1	1.1
2025	4	26	5	35	24	0	0	0	0	0	0	0	13.84	0	0	11.6	0.1	1.1
2025	4	26	5	45	24	0	0	0	0	0	0	0	13.84	0	0	11.6	0.1	1.1
2025	4	26	5	55	24	0	0	0	0	0	0	0	13.85	0	0	11.6	0.1	1.1
2025	4	26	6	5	24	0	0	0	0	0	0	0	13.85	0	0	11.6	0.1	1.1
2025	4	26	6	15	24	0	0	0	0	0	0	0	13.86	0	0	11.6	0.1	1.1
2025	4	26	6	25	24	0	0	0	0	0	0	0	13.87	0	0	11.6	0.1	1.1
2025	4	26	6	35	24	0	0	0	0	0	0	0	13.86	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	26	6	45	24	0	0	0	0	0	0	0	13.86	0	0	11.6	0.1	1.1
2025	4	26	6	55	24	0	0	0	0	0	0	0	13.87	0	0	11.6	0.1	1.1
2025	4	26	7	5	24	0	0	0	0	0	0	0	13.87	0	0	11.6	0.1	1.1
2025	4	26	7	15	24	0	0	0	0	0	0	0	13.87	0	0	11.8	0.1	1.1
2025	4	26	7	25	24	0	0	0	0	0	0	0	13.87	0	0	11.8	0.1	1.1
2025	4	26	7	35	24	0	0	0	0	0	0	0	13.87	0	0	12	0.1	1.1
2025	4	26	7	45	24	0	0	0	0	0	0	0	13.88	0	0	12.2	0.1	1.1
2025	4	26	7	55	24	0	0	0	0	0	0	0	13.89	0	0	12.4	0.1	1.1
2025	4	26	8	5	24	0	0	0	0	0	0	0	13.9	0	0	12.6	0.1	1.1
2025	4	26	8	15	24	0	0	0	0	0	0	0	13.92	0	0	12.8	0.1	1.1
2025	4	26	8	25	24	0	0	0	0	0	0	0	13.93	0	0	12.8	0.1	1.1
2025	4	26	8	35	24	0	0	0	0	0	0	0	13.95	0	0	12.8	0.1	1.1
2025	4	26	8	45	24	0	0	0	0	0	0	0	13.97	0	0	13	0.1	1.1
2025	4	26	8	55	24	0	0	0	0	0	0	0	14	0	0	13	0.1	1.1
2025	4	26	9	5	24	0	0	0	0	0	0	0	14.02	0	0	13.2	0.1	1.1
2025	4	26	9	15	24	0	0	0	0	0	0	0	14.04	0	0	13.2	0.1	1.1
2025	4	26	9	25	24	0	0	0	0	0	0	0	14.06	0	0	13.4	0.1	1.1
2025	4	26	9	35	24	0	0	0	0	0	0	0	14.09	0	0	13.8	0.1	1.1
2025	4	26	9	45	24	0	0	0	0	0	0	0	14.11	0	0	13.8	0.1	1.1
2025	4	26	9	55	24	0	0	0	0	0	0	0	14.14	0	0	13.8	0.1	1.1
2025	4	26	10	5	24	0	0	0	0	0	0	0	14.17	0	0	13.8	0.1	1.1
2025	4	26	10	15	24	0	0	0	0	0	0	0	14.14	0	0	13	0.1	1.1
2025	4	26	10	25	24	0	0	0	0	0	0	0	14.14	0	0	13.8	0.1	1.1
2025	4	26	10	35	24	0	0	0	0	0	0	0	14.13	0	0	13.6	0.1	1.1
2025	4	26	10	45	24	0	0	0	0	0	0	0	14.17	0	0	13.8	0.1	1.1
2025	4	26	10	55	24	0	0	0	0	0	0	0	14.23	0	0	13.8	0.1	1.1
2025	4	26	11	5	24	0	0	0	0	0	0	0	14.28	0	0	13.8	0.1	1.1
2025	4	26	11	15	24	0	0	0	0	0	0	0	14.3	0	0	13.6	0.1	1.1
2025	4	26	11	25	24	0	0	0	0	0	0	0	14.29	0	0	13.6	0.1	1.1
2025	4	26	11	35	24	0	0	0	0	0	0	0	14.27	0	0	13.8	0.1	1.1
2025	4	26	11	45	24	0	0	0	0	0	0	0	14.3	0	0	13.8	0.1	1.1
2025	4	26	11	55	24	0	0	0	0	0	0	0	14.28	0	0	13.8	0.1	1.1
2025	4	26	12	5	24	0	0	0	0	0	0	0	14.26	0	0	13.4	0.1	1.1
2025	4	26	12	15	24	0	0	0	0	0	0	0	14.22	0	0	12.6	0.1	1.1
2025	4	26	12	25	24	0	0	0	0	0	0	0	14.18	0	0	12.4	0.1	1.1
2025	4	26	12	35	24	0	0	0	0	0	0	0	14.17	0	0	12.6	0.1	1.1
2025	4	26	12	45	24	0	0	0	0	0	0	0	14.15	0	0	13.6	0.1	1.1
2025	4	26	12	55	24	0	0	0	0	0	0	0	14.16	0	0	13.8	0.1	1.1
2025	4	26	13	5	24	0	0	0	0	0	0	0	14.21	0	0	13.8	0.1	1.1
2025	4	26	13	15	24	0	0	0	0	0	0	0	14.27	0	0	13.8	0.1	1.1
2025	4	26	13	25	24	0	0	0	0	0	0	0	14.29	0	0	13.8	0.1	1.1
2025	4	26	13	35	24	0	0	0	0	0	0	0	14.26	0	0	13.8	0.1	1.1
2025	4	26	13	45	24	0	0	0	0	0	0	0	14.23	0	0	13.8	0.1	1.1
2025	4	26	13	55	24	0	0	0	0	0	0	0	14.29	0	0	13.8	0.1	1.1
2025	4	26	14	5	24	0	0	0	0	0	0	0	14.27	0	0	13.8	0.1	1.1
2025	4	26	14	15	24	0	0	0	0	0	0	0	14.29	0	0	13.8	0.1	1.1
2025	4	26	14	25	24	0	0	0	0	0	0	0	14.25	0	0	13.8	0.1	1.1
2025	4	26	14	35	24	0	0	0	0	0	0	0	14.28	0	0	13.8	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	26	14	45	24	0	0	0	0	0	0	0	14.29	0	0	13.8	0.1	1.1
2025	4	26	14	55	24	0	0	0	0	0	0	0	14.25	0	0	13.8	0.1	1.1
2025	4	26	15	5	24	0	0	0	0	0	0	0	14.26	0	0	13.8	0.1	1.1
2025	4	26	15	15	24	0	0	0	0	0	0	0	14.23	0	0	13.8	0.1	1.1
2025	4	26	15	25	24	0	0	0	0	0	0	0	14.18	0	0	13.6	0.1	1.1
2025	4	26	15	35	24	0	0	0	0	0	0	0	14.16	0	0	13.8	0.1	1.1
2025	4	26	15	45	24	0	0	0	0	0	0	0	14.13	0	0	13.8	0.1	1.1
2025	4	26	15	55	24	0	0	0	0	0	0	0	14.12	0	0	13.8	0.1	1.1
2025	4	26	16	5	24	0	0	0	0	0	0	0	14.07	0	0	13	0.1	1.1
2025	4	26	16	15	24	0	0	0	0	0	0	0	14.03	0	0	12.8	0.1	1.1
2025	4	26	16	25	24	0	0	0	0	0	0	0	14	0	0	12.8	0.1	1.1
2025	4	26	16	35	24	0	0	0	0	0	0	0	13.97	0	0	12.6	0.1	1.1
2025	4	26	16	45	24	0	0	0	0	0	0	0	13.93	0	0	12.6	0.1	1.1
2025	4	26	16	55	24	0	0	0	0	0	0	0	13.9	0	0	12.6	0.1	1.1
2025	4	26	17	5	24	0	0	0	0	0	0	0	13.86	0	0	12.4	0.1	1.1
2025	4	26	17	15	24	0	0	0	0	0	0	0	13.83	0	0	12.2	0.1	1.1
2025	4	26	17	25	24	0	0	0	0	0	0	0	13.81	0	0	12.2	0.1	1.1
2025	4	26	17	35	24	0	0	0	0	0	0	0	13.77	0	0	12	0.1	1.1
2025	4	26	17	45	24	0	0	0	0	0	0	0	13.73	0	0	11.8	0.1	1.1
2025	4	26	17	55	24	0	0	0	0	0	0	0	13.69	0	0	11.8	0.1	1.1
2025	4	26	18	5	24	0	0	0	0	0	0	0	13.65	0	0	11.8	0.1	1.1
2025	4	26	18	15	24	0	0	0	0	0	0	0	13.61	0	0	11.8	0.1	1.1
2025	4	26	18	25	24	0	0	0	0	0	0	0	13.57	0	0	11.8	0.1	1.1
2025	4	26	18	35	24	0	0	0	0	0	0	0	13.53	0	0	11.8	0.1	1.1
2025	4	26	18	45	24	0	0	0	0	0	0	0	13.48	0	0	11.8	0.1	1.1
2025	4	26	18	55	24	0	0	0	0	0	0	0	13.44	0	0	11.8	0.1	1.1
2025	4	26	19	5	24	0	0	0	0	0	0	0	13.41	0	0	11.8	0.1	1.1
2025	4	26	19	15	24	0	0	0	0	0	0	0	13.37	0	0	11.8	0.1	1.1
2025	4	26	19	25	24	0	0	0	0	0	0	0	13.33	0	0	11.8	0.1	1.1
2025	4	26	19	35	24	0	0	0	0	0	0	0	13.29	0	0	11.8	0.1	1.1
2025	4	26	19	45	24	0	0	0	0	0	0	0	13.26	0	0	11.8	0.1	1.1
2025	4	26	19	55	24	0	0	0	0	0	0	0	13.22	0	0	11.8	0.1	1.1
2025	4	26	20	5	24	0	0	0	0	0	0	0	13.18	0	0	11.8	0.1	1.1
2025	4	26	20	15	24	0	0	0	0	0	0	0	13.13	0	0	11.8	0.1	1.1
2025	4	26	20	25	24	0	0	0	0	0	0	0	13.09	0	0	11.8	0.1	1.1
2025	4	26	20	35	24	0	0	0	0	0	0	0	13.05	0	0	11.8	0.1	1.1
2025	4	26	20	45	24	0	0	0	0	0	0	0	13.01	0	0	11.8	0.1	1.1
2025	4	26	20	55	24	0	0	0	0	0	0	0	12.97	0	0	11.8	0.1	1.1
2025	4	26	21	5	24	0	0	0	0	0	0	0	12.93	0	0	11.8	0.1	1.1
2025	4	26	21	15	24	0	0	0	0	0	0	0	12.89	0	0	11.8	0.1	1.1
2025	4	26	21	25	24	0	0	0	0	0	0	0	12.85	0	0	11.8	0.1	1.1
2025	4	26	21	35	24	0	0	0	0	0	0	0	12.82	0	0	11.6	0.1	1.1
2025	4	26	21	45	24	0	0	0	0	0	0	0	12.79	0	0	11.6	0.1	1.1
2025	4	26	21	55	24	0	0	0	0	0	0	0	12.76	0	0	11.6	0.1	1.1
2025	4	26	22	5	24	0	0	0	0	0	0	0	12.74	0	0	11.6	0.1	1.1
2025	4	26	22	15	24	0	0	0	0	0	0	0	12.71	0	0	11.6	0.1	1.1
2025	4	26	22	25	24	0	0	0	0	0	0	0	12.69	0	0	11.6	0.1	1.1
2025	4	26	22	35	24	0	0	0	0	0	0	0	12.66	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	26	22	45	24	0	0	0	0	0	0	0	12.64	0	0	11.6	0.1	1.1
2025	4	26	22	55	24	0	0	0	0	0	0	0	12.61	0	0	11.6	0.1	1.1
2025	4	26	23	5	24	0	0	0	0	0	0	0	12.59	0	0	11.6	0.1	1.1
2025	4	26	23	15	24	0	0	0	0	0	0	0	12.56	0	0	11.6	0.1	1.1
2025	4	26	23	25	24	0	0	0	0	0	0	0	12.54	0	0	11.6	0.1	1.1
2025	4	26	23	35	24	0	0	0	0	0	0	0	12.52	0	0	11.6	0.1	1.1
2025	4	26	23	45	24	0	0	0	0	0	0	0	12.5	0	0	11.6	0.1	1.1
2025	4	26	23	55	24	0	0	0	0	0	0	0	12.47	0	0	11.6	0.1	1.1
2025	4	27	0	5	24	0	0	0	0	0	0	0	12.45	0	0	11.6	0.1	1.1
2025	4	27	0	15	24	0	0	0	0	0	0	0	12.43	0	0	11.6	0.1	1.1
2025	4	27	0	25	24	0	0	0	0	0	0	0	12.41	0	0	11.6	0.1	1.1
2025	4	27	0	35	24	0	0	0	0	0	0	0	12.39	0	0	11.6	0.1	1.1
2025	4	27	0	45	24	0	0	0	0	0	0	0	12.37	0	0	11.6	0.1	1.1
2025	4	27	0	55	24	0	0	0	0	0	0	0	12.35	0	0	11.6	0.1	1.1
2025	4	27	1	5	24	0	0	0	0	0	0	0	12.34	0	0	11.6	0.1	1.1
2025	4	27	1	15	24	0	0	0	0	0	0	0	12.32	0	0	11.6	0.1	1.1
2025	4	27	1	25	24	0	0	0	0	0	0	0	12.3	0	0	11.6	0.1	1.1
2025	4	27	1	35	24	0	0	0	0	0	0	0	12.29	0	0	11.6	0.1	1.1
2025	4	27	1	45	24	0	0	0	0	0	0	0	12.27	0	0	11.6	0.1	1.1
2025	4	27	1	55	24	0	0	0	0	0	0	0	12.25	0	0	11.6	0.1	1.1
2025	4	27	2	5	24	0	0	0	0	0	0	0	12.23	0	0	11.6	0.1	1.1
2025	4	27	2	15	24	0	0	0	0	0	0	0	12.22	0	0	11.6	0.1	1.1
2025	4	27	2	25	24	0	0	0	0	0	0	0	12.2	0	0	11.6	0.1	1.1
2025	4	27	2	35	24	0	0	0	0	0	0	0	12.18	0	0	11.6	0.1	1.1
2025	4	27	2	45	24	0	0	0	0	0	0	0	12.17	0	0	11.6	0.1	1.1
2025	4	27	2	55	24	0	0	0	0	0	0	0	12.15	0	0	11.6	0.1	1.1
2025	4	27	3	5	24	0	0	0	0	0	0	0	12.14	0	0	11.6	0.1	1.1
2025	4	27	3	15	24	0	0	0	0	0	0	0	12.12	0	0	11.6	0.1	1.1
2025	4	27	3	25	24	0	0	0	0	0	0	0	12.1	0	0	11.6	0.1	1.1
2025	4	27	3	35	24	0	0	0	0	0	0	0	12.09	0	0	11.6	0.1	1.1
2025	4	27	3	45	24	0	0	0	0	0	0	0	12.07	0	0	11.6	0.1	1.1
2025	4	27	3	55	24	0	0	0	0	0	0	0	12.06	0	0	11.6	0.1	1.1
2025	4	27	4	5	24	0	0	0	0	0	0	0	12.05	0	0	11.4	0.1	1.1
2025	4	27	4	15	24	0	0	0	0	0	0	0	12.03	0	0	11.4	0.1	1.1
2025	4	27	4	25	24	0	0	0	0	0	0	0	12.02	0	0	11.4	0.1	1.1
2025	4	27	4	35	24	0	0	0	0	0	0	0	12.01	0	0	11.4	0.1	1.1
2025	4	27	4	45	24	0	0	0	0	0	0	0	12	0	0	11.4	0.1	1.1
2025	4	27	4	55	24	0	0	0	0	0	0	0	11.99	0	0	11.4	0.1	1.1
2025	4	27	5	5	24	0	0	0	0	0	0	0	11.98	0	0	11.4	0.1	1.1
2025	4	27	5	15	24	0	0	0	0	0	0	0	11.96	0	0	11.4	0.1	1.1
2025	4	27	5	25	24	0	0	0	0	0	0	0	11.94	0	0	11.4	0.1	1.1
2025	4	27	5	35	24	0	0	0	0	0	0	0	11.93	0	0	11.4	0.1	1.1
2025	4	27	5	45	24	0	0	0	0	0	0	0	11.92	0	0	11.4	0.1	1.1
2025	4	27	5	55	24	0	0	0	0	0	0	0	11.91	0	0	11.4	0.1	1.1
2025	4	27	6	5	24	0	0	0	0	0	0	0	11.89	0	0	11.4	0.1	1.1
2025	4	27	6	15	24	0	0	0	0	0	0	0	11.88	0	0	11.4	0.1	1.1
2025	4	27	6	25	24	0	0	0	0	0	0	0	11.87	0	0	11.4	0.1	1.1
2025	4	27	6	35	24	0	0	0	0	0	0	0	11.86	0	0	11.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	27	6	45	24	0	0	0	0	0	0	0	11.85	0	0	11.4	0.1	1.1
2025	4	27	6	55	24	0	0	0	0	0	0	0	11.85	0	0	11.6	0.1	1.1
2025	4	27	7	5	24	0	0	0	0	0	0	0	11.85	0	0	11.8	0.1	1.1
2025	4	27	7	15	24	0	0	0	0	0	0	0	11.84	0	0	11.8	0.1	1.1
2025	4	27	7	25	24	0	0	0	0	0	0	0	11.85	0	0	11.8	0.1	1.1
2025	4	27	7	35	24	0	0	0	0	0	0	0	11.86	0	0	12.2	0.1	1.1
2025	4	27	7	45	24	0	0	0	0	0	0	0	11.88	0	0	12.6	0.1	1.1
2025	4	27	7	55	24	0	0	0	0	0	0	0	11.88	0	0	12.6	0.1	1.1
2025	4	27	8	5	24	0	0	0	0	0	0	0	11.89	0	0	12.6	0.1	1.1
2025	4	27	8	15	24	0	0	0	0	0	0	0	11.92	0	0	12.8	0.1	1.1
2025	4	27	8	25	24	0	0	0	0	0	0	0	11.94	0	0	13	0.1	1.1
2025	4	27	8	35	24	0	0	0	0	0	0	0	11.96	0	0	13	0.1	1.1
2025	4	27	8	45	24	0	0	0	0	0	0	0	11.99	0	0	13	0.1	1.1
2025	4	27	8	55	24	0	0	0	0	0	0	0	12.01	0	0	13	0.1	1.1
2025	4	27	9	5	24	0	0	0	0	0	0	0	12.04	0	0	13.2	0.1	1.1
2025	4	27	9	15	24	0	0	0	0	0	0	0	12.08	0	0	13.4	0.1	1.1
2025	4	27	9	25	24	0	0	0	0	0	0	0	12.1	0	0	13.6	0.1	1.1
2025	4	27	9	35	24	0	0	0	0	0	0	0	12.15	0	0	13.8	0.1	1.1
2025	4	27	9	45	24	0	0	0	0	0	0	0	12.19	0	0	14	0.1	1.1
2025	4	27	9	55	24	0	0	0	0	0	0	0	12.23	0	0	13.8	0.1	1.1
2025	4	27	10	5	24	0	0	0	0	0	0	0	12.26	0	0	13.8	0.1	1.1
2025	4	27	10	15	24	0	0	0	0	0	0	0	12.3	0	0	13.8	0.1	1.1
2025	4	27	10	25	24	0	0	0	0	0	0	0	12.34	0	0	13.8	0.1	1.1
2025	4	27	10	35	24	0	0	0	0	0	0	0	12.39	0	0	13.6	0.1	1.1
2025	4	27	10	45	24	0	0	0	0	0	0	0	12.43	0	0	13.6	0.1	1.1
2025	4	27	10	55	24	0	0	0	0	0	0	0	12.47	0	0	13.6	0.1	1.1
2025	4	27	11	5	24	0	0	0	0	0	0	0	12.53	0	0	13.6	0.1	1.1
2025	4	27	11	15	24	0	0	0	0	0	0	0	12.57	0	0	13.6	0.1	1.1
2025	4	27	11	25	24	0	0	0	0	0	0	0	12.61	0	0	13.6	0.1	1.1
2025	4	27	11	35	24	0	0	0	0	0	0	0	12.66	0	0	13.6	0.1	1.1
2025	4	27	11	45	24	0	0	0	0	0	0	0	12.7	0	0	13.6	0.1	1.1
2025	4	27	11	55	24	0	0	0	0	0	0	0	12.76	0	0	13.6	0.1	1.1
2025	4	27	12	5	24	0	0	0	0	0	0	0	12.8	0	0	13.6	0.1	1.1
2025	4	27	12	15	24	0	0	0	0	0	0	0	12.85	0	0	13.6	0.1	1.1
2025	4	27	12	25	24	0	0	0	0	0	0	0	12.88	0	0	13.6	0.1	1.1
2025	4	27	12	35	24	0	0	0	0	0	0	0	12.93	0	0	13.6	0.1	1.1
2025	4	27	12	45	24	0	0	0	0	0	0	0	12.98	0	0	13.6	0.1	1.1
2025	4	27	12	55	24	0	0	0	0	0	0	0	13.02	0	0	13.6	0.1	1.1
2025	4	27	13	5	24	0	0	0	0	0	0	0	13.06	0	0	13.6	0.1	1.1
2025	4	27	13	15	24	0	0	0	0	0	0	0	13.09	0	0	13.6	0.1	1.1
2025	4	27	13	25	24	0	0	0	0	0	0	0	13.13	0	0	13.6	0.1	1.1
2025	4	27	13	35	24	0	0	0	0	0	0	0	13.16	0	0	13.6	0.1	1.1
2025	4	27	13	45	24	0	0	0	0	0	0	0	13.2	0	0	13.6	0.1	1.1
2025	4	27	13	55	24	0	0	0	0	0	0	0	13.23	0	0	13.6	0.1	1.1
2025	4	27	14	5	24	0	0	0	0	0	0	0	13.27	0	0	13.6	0.1	1.1
2025	4	27	14	15	24	0	0	0	0	0	0	0	13.29	0	0	13.6	0.1	1.1
2025	4	27	14	25	24	0	0	0	0	0	0	0	13.32	0	0	13.6	0.1	1.1
2025	4	27	14	35	24	0	0	0	0	0	0	0	13.34	0	0	13.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	27	14	45	24	0	0	0	0	0	0	0	13.36	0	0	13.6	0.1	1.1
2025	4	27	14	55	24	0	0	0	0	0	0	0	13.38	0	0	13.6	0.1	1.1
2025	4	27	15	5	24	0	0	0	0	0	0	0	13.39	0	0	13.6	0.1	1.1
2025	4	27	15	15	24	0	0	0	0	0	0	0	13.41	0	0	13.6	0.1	1.1
2025	4	27	15	25	24	0	0	0	0	0	0	0	13.43	0	0	13.4	0.1	1.1
2025	4	27	15	35	24	0	0	0	0	0	0	0	13.43	0	0	13.6	0.1	1.1
2025	4	27	15	45	24	0	0	0	0	0	0	0	13.44	0	0	13.4	0.1	1.1
2025	4	27	15	55	24	0	0	0	0	0	0	0	13.45	0	0	13.4	0.1	1.1
2025	4	27	16	5	24	0	0	0	0	0	0	0	13.46	0	0	13.4	0.1	1.1
2025	4	27	16	15	24	0	0	0	0	0	0	0	13.46	0	0	13.4	0.1	1.1
2025	4	27	16	25	24	0	0	0	0	0	0	0	13.49	0	0	13.4	0.1	1.1
2025	4	27	16	35	24	0	0	0	0	0	0	0	13.49	0	0	13.4	0.1	1.1
2025	4	27	16	45	24	0	0	0	0	0	0	0	13.5	0	0	13.4	0.1	1.1
2025	4	27	16	55	24	0	0	0	0	0	0	0	13.51	0	0	13.4	0.1	1.1
2025	4	27	17	5	24	0	0	0	0	0	0	0	13.52	0	0	13.4	0.1	1.1
2025	4	27	17	15	24	0	0	0	0	0	0	0	13.5	0	0	13.2	0.1	1.1
2025	4	27	17	25	24	0	0	0	0	0	0	0	13.48	0	0	12.8	0.1	1.1
2025	4	27	17	35	24	0	0	0	0	0	0	0	13.47	0	0	12.6	0.1	1.1
2025	4	27	17	45	24	0	0	0	0	0	0	0	13.45	0	0	12.6	0.1	1.1
2025	4	27	17	55	24	0	0	0	0	0	0	0	13.42	0	0	12.4	0.1	1.1
2025	4	27	18	5	24	0	0	0	0	0	0	0	13.39	0	0	12.2	0.1	1.1
2025	4	27	18	15	24	0	0	0	0	0	0	0	13.36	0	0	12	0.1	1.1
2025	4	27	18	25	24	0	0	0	0	0	0	0	13.33	0	0	12	0.1	1.1
2025	4	27	18	35	24	0	0	0	0	0	0	0	13.31	0	0	12	0.1	1.1
2025	4	27	18	45	24	0	0	0	0	0	0	0	13.27	0	0	11.8	0.1	1.1
2025	4	27	18	55	24	0	0	0	0	0	0	0	13.24	0	0	11.8	0.1	1.1
2025	4	27	19	5	24	0	0	0	0	0	0	0	13.21	0	0	11.8	0.1	1.1
2025	4	27	19	15	24	0	0	0	0	0	0	0	13.17	0	0	11.8	0.1	1.1
2025	4	27	19	25	24	0	0	0	0	0	0	0	13.14	0	0	11.8	0.1	1.1
2025	4	27	19	35	24	0	0	0	0	0	0	0	13.11	0	0	11.8	0.1	1.1
2025	4	27	19	45	24	0	0	0	0	0	0	0	13.07	0	0	11.8	0.1	1.1
2025	4	27	19	55	24	0	0	0	0	0	0	0	13.04	0	0	11.8	0.1	1.1
2025	4	27	20	5	24	0	0	0	0	0	0	0	13	0	0	11.8	0.1	1.1
2025	4	27	20	15	24	0	0	0	0	0	0	0	12.97	0	0	11.8	0.1	1.1
2025	4	27	20	25	24	0	0	0	0	0	0	0	12.93	0	0	11.8	0.1	1.1
2025	4	27	20	35	24	0	0	0	0	0	0	0	12.89	0	0	11.8	0.1	1.1
2025	4	27	20	45	24	0	0	0	0	0	0	0	12.85	0	0	11.8	0.1	1.1
2025	4	27	20	55	24	0	0	0	0	0	0	0	12.8	0	0	11.8	0.1	1.1
2025	4	27	21	5	24	0	0	0	0	0	0	0	12.76	0	0	11.8	0.1	1.1
2025	4	27	21	15	24	0	0	0	0	0	0	0	12.73	0	0	11.8	0.1	1.1
2025	4	27	21	25	24	0	0	0	0	0	0	0	12.69	0	0	11.8	0.1	1.1
2025	4	27	21	35	24	0	0	0	0	0	0	0	12.65	0	0	11.8	0.1	1.1
2025	4	27	21	45	24	0	0	0	0	0	0	0	12.62	0	0	11.8	0.1	1.1
2025	4	27	21	55	24	0	0	0	0	0	0	0	12.59	0	0	11.8	0.1	1.1
2025	4	27	22	5	24	0	0	0	0	0	0	0	12.56	0	0	11.8	0.1	1.1
2025	4	27	22	15	24	0	0	0	0	0	0	0	12.54	0	0	11.8	0.1	1.1
2025	4	27	22	25	24	0	0	0	0	0	0	0	12.5	0	0	11.8	0.1	1.1
2025	4	27	22	35	24	0	0	0	0	0	0	0	12.48	0	0	11.8	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	27	22	45	24	0	0	0	0	0	0	0	12.45	0	0	11.8	0.1	1.1
2025	4	27	22	55	24	0	0	0	0	0	0	0	12.44	0	0	11.8	0.1	1.1
2025	4	27	23	5	24	0	0	0	0	0	0	0	12.41	0	0	11.8	0.1	1.1
2025	4	27	23	15	24	0	0	0	0	0	0	0	12.4	0	0	11.8	0.1	1.1
2025	4	27	23	25	24	0	0	0	0	0	0	0	12.38	0	0	11.6	0.1	1.1
2025	4	27	23	35	24	0	0	0	0	0	0	0	12.36	0	0	11.6	0.1	1.1
2025	4	27	23	45	24	0	0	0	0	0	0	0	12.35	0	0	11.6	0.1	1.1
2025	4	27	23	55	24	0	0	0	0	0	0	0	12.33	0	0	11.6	0.1	1.1
2025	4	28	0	5	24	0	0	0	0	0	0	0	12.32	0	0	11.6	0.1	1.1
2025	4	28	0	15	24	0	0	0	0	0	0	0	12.31	0	0	11.6	0.1	1.1
2025	4	28	0	25	24	0	0	0	0	0	0	0	12.3	0	0	11.6	0.1	1.1
2025	4	28	0	35	24	0	0	0	0	0	0	0	12.29	0	0	11.6	0.1	1.1
2025	4	28	0	45	24	0	0	0	0	0	0	0	12.27	0	0	11.6	0.1	1.1
2025	4	28	0	55	24	0	0	0	0	0	0	0	12.26	0	0	11.6	0.1	1.1
2025	4	28	1	5	24	0	0	0	0	0	0	0	12.25	0	0	11.6	0.1	1.1
2025	4	28	1	15	24	0	0	0	0	0	0	0	12.25	0	0	11.6	0.1	1.1
2025	4	28	1	25	24	0	0	0	0	0	0	0	12.24	0	0	11.6	0.1	1.1
2025	4	28	1	35	24	0	0	0	0	0	0	0	12.24	0	0	11.6	0.1	1.1
2025	4	28	1	45	24	0	0	0	0	0	0	0	12.23	0	0	11.6	0.1	1.1
2025	4	28	1	55	24	0	0	0	0	0	0	0	12.24	0	0	11.6	0.1	1.1
2025	4	28	2	5	24	0	0	0	0	0	0	0	12.23	0	0	11.6	0.1	1.1
2025	4	28	2	15	24	0	0	0	0	0	0	0	12.23	0	0	11.6	0.1	1.1
2025	4	28	2	25	24	0	0	0	0	0	0	0	12.24	0	0	11.6	0.1	1.1
2025	4	28	2	35	24	0	0	0	0	0	0	0	12.24	0	0	11.6	0.1	1.1
2025	4	28	2	45	24	0	0	0	0	0	0	0	12.24	0	0	11.6	0.1	1.1
2025	4	28	2	55	24	0	0	0	0	0	0	0	12.24	0	0	11.6	0.1	1.1
2025	4	28	3	5	24	0	0	0	0	0	0	0	12.25	0	0	11.6	0.1	1.1
2025	4	28	3	15	24	0	0	0	0	0	0	0	12.26	0	0	11.6	0.1	1.1
2025	4	28	3	25	24	0	0	0	0	0	0	0	12.27	0	0	11.6	0.1	1.1
2025	4	28	3	35	24	0	0	0	0	0	0	0	12.28	0	0	11.6	0.1	1.1
2025	4	28	3	45	24	0	0	0	0	0	0	0	12.29	0	0	11.6	0.1	1.1
2025	4	28	3	55	24	0	0	0	0	0	0	0	12.31	0	0	11.6	0.1	1.1
2025	4	28	4	5	24	0	0	0	0	0	0	0	12.32	0	0	11.6	0.1	1.1
2025	4	28	4	15	24	0	0	0	0	0	0	0	12.34	0	0	11.6	0.1	1.1
2025	4	28	4	25	24	0	0	0	0	0	0	0	12.36	0	0	11.6	0.1	1.1
2025	4	28	4	35	24	0	0	0	0	0	0	0	12.37	0	0	11.6	0.1	1.1
2025	4	28	4	45	24	0	0	0	0	0	0	0	12.39	0	0	11.6	0.1	1.1
2025	4	28	4	55	24	0	0	0	0	0	0	0	12.41	0	0	11.6	0.1	1.1
2025	4	28	5	5	24	0	0	0	0	0	0	0	12.43	0	0	11.6	0.1	1.1
2025	4	28	5	15	24	0	0	0	0	0	0	0	12.45	0	0	11.6	0.1	1.1
2025	4	28	5	25	24	0	0	0	0	0	0	0	12.46	0	0	11.6	0.1	1.1
2025	4	28	5	35	24	0	0	0	0	0	0	0	12.48	0	0	11.6	0.1	1.1
2025	4	28	5	45	24	0	0	0	0	0	0	0	12.5	0	0	11.6	0.1	1.1
2025	4	28	5	55	24	0	0	0	0	0	0	0	12.52	0	0	11.6	0.1	1.1
2025	4	28	6	5	24	0	0	0	0	0	0	0	12.53	0	0	11.6	0.1	1.1
2025	4	28	6	15	24	0	0	0	0	0	0	0	12.54	0	0	11.6	0.1	1.1
2025	4	28	6	25	24	0	0	0	0	0	0	0	12.55	0	0	11.6	0.1	1.1
2025	4	28	6	35	24	0	0	0	0	0	0	0	12.57	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	28	6	45	24	0	0	0	0	0	0	0	12.58	0	0	11.6	0.1	1.1
2025	4	28	6	55	24	0	0	0	0	0	0	0	12.59	0	0	11.6	0.1	1.1
2025	4	28	7	5	24	0	0	0	0	0	0	0	12.6	0	0	11.6	0.1	1.1
2025	4	28	7	15	24	0	0	0	0	0	0	0	12.62	0	0	11.8	0.1	1.1
2025	4	28	7	25	24	0	0	0	0	0	0	0	12.64	0	0	11.8	0.1	1.1
2025	4	28	7	35	24	0	0	0	0	0	0	0	12.67	0	0	12	0.1	1.1
2025	4	28	7	45	24	0	0	0	0	0	0	0	12.7	0	0	12.2	0.1	1.1
2025	4	28	7	55	24	0	0	0	0	0	0	0	12.73	0	0	12.4	0.1	1.1
2025	4	28	8	5	24	0	0	0	0	0	0	0	12.76	0	0	12.6	0.1	1.1
2025	4	28	8	15	24	0	0	0	0	0	0	0	12.81	0	0	12.6	0.1	1.1
2025	4	28	8	25	24	0	0	0	0	0	0	0	12.84	0	0	12.8	0.1	1.1
2025	4	28	8	35	24	0	0	0	0	0	0	0	12.89	0	0	12.8	0.1	1.1
2025	4	28	8	45	24	0	0	0	0	0	0	0	12.93	0	0	12.8	0.1	1.1
2025	4	28	8	55	24	0	0	0	0	0	0	0	12.97	0	0	13	0.1	1.1
2025	4	28	9	5	24	0	0	0	0	0	0	0	13.02	0	0	13	0.1	1.1
2025	4	28	9	15	24	0	0	0	0	0	0	0	13.07	0	0	13.2	0.1	1.1
2025	4	28	9	25	24	0	0	0	0	0	0	0	13.1	0	0	13.2	0.1	1.1
2025	4	28	9	35	24	0	0	0	0	0	0	0	13.15	0	0	13.6	0.1	1.1
2025	4	28	9	45	24	0	0	0	0	0	0	0	13.21	0	0	13.6	0.1	1.1
2025	4	28	9	55	24	0	0	0	0	0	0	0	13.26	0	0	13.6	0.1	1.1
2025	4	28	10	5	24	0	0	0	0	0	0	0	13.31	0	0	13.6	0.1	1.1
2025	4	28	10	15	24	0	0	0	0	0	0	0	13.37	0	0	13.6	0.1	1.1
2025	4	28	10	25	24	0	0	0	0	0	0	0	13.42	0	0	13.6	0.1	1.1
2025	4	28	10	35	24	0	0	0	0	0	0	0	13.48	0	0	13.6	0.1	1.1
2025	4	28	10	45	24	0	0	0	0	0	0	0	13.54	0	0	13.6	0.1	1.1
2025	4	28	10	55	24	0	0	0	0	0	0	0	13.6	0	0	13.6	0.1	1.1
2025	4	28	11	5	24	0	0	0	0	0	0	0	13.65	0	0	13.6	0.1	1.1
2025	4	28	11	15	24	0	0	0	0	0	0	0	13.71	0	0	13.6	0.1	1.1
2025	4	28	11	25	24	0	0	0	0	0	0	0	13.76	0	0	13.6	0.1	1.1
2025	4	28	11	35	24	0	0	0	0	0	0	0	13.81	0	0	13.6	0.1	1.1
2025	4	28	11	45	24	0	0	0	0	0	0	0	13.86	0	0	13.6	0.1	1.1
2025	4	28	11	55	24	0	0	0	0	0	0	0	13.92	0	0	13.4	0.1	1.1
2025	4	28	12	5	24	0	0	0	0	0	0	0	13.98	0	0	13.4	0.1	1.1
2025	4	28	12	15	24	0	0	0	0	0	0	0	14.03	0	0	13.4	0.1	1.1
2025	4	28	12	25	24	0	0	0	0	0	0	0	14.08	0	0	13.4	0.1	1.1
2025	4	28	12	35	24	0	0	0	0	0	0	0	14.13	0	0	13.4	0.1	1.1
2025	4	28	12	45	24	0	0	0	0	0	0	0	14.16	0	0	13.4	0.1	1.1
2025	4	28	12	55	24	0	0	0	0	0	0	0	14.23	0	0	13.4	0.1	1.1
2025	4	28	13	5	24	0	0	0	0	0	0	0	14.28	0	0	13.4	0.1	1.1
2025	4	28	13	15	24	0	0	0	0	0	0	0	14.31	0	0	13.2	0.1	1.1
2025	4	28	13	25	24	0	0	0	0	0	0	0	14.32	0	0	13.4	0.1	1.1
2025	4	28	13	35	24	0	0	0	0	0	0	0	14.42	0	0	13.4	0.1	1.1
2025	4	28	13	45	24	0	0	0	0	0	0	0	14.44	0	0	13.4	0.1	1.1
2025	4	28	13	55	24	0	0	0	0	0	0	0	14.39	0	0	13.4	0.1	1.1
2025	4	28	14	5	24	0	0	0	0	0	0	0	14.37	0	0	13.4	0.1	1.1
2025	4	28	14	15	24	0	0	0	0	0	0	0	14.37	0	0	13.4	0.1	1.1
2025	4	28	14	25	24	0	0	0	0	0	0	0	14.36	0	0	13.4	0.1	1.1
2025	4	28	14	35	24	0	0	0	0	0	0	0	14.37	0	0	13.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	28	14	45	24	0	0	0	0	0	0	0	14.43	0	0	13.4	0.1	1.1
2025	4	28	14	55	24	0	0	0	0	0	0	0	14.43	0	0	13.4	0.1	1.1
2025	4	28	15	5	24	0	0	0	0	0	0	0	14.43	0	0	13.4	0.1	1.1
2025	4	28	15	15	24	0	0	0	0	0	0	0	14.43	0	0	13.4	0.1	1.1
2025	4	28	15	25	24	0	0	0	0	0	0	0	14.47	0	0	13.4	0.1	1.1
2025	4	28	15	35	24	0	0	0	0	0	0	0	14.47	0	0	13.2	0.1	1.1
2025	4	28	15	45	24	0	0	0	0	0	0	0	14.47	0	0	13.4	0.1	1.1
2025	4	28	15	55	24	0	0	0	0	0	0	0	14.45	0	0	13.2	0.1	1.1
2025	4	28	16	5	24	0	0	0	0	0	0	0	14.44	0	0	12.8	0.1	1.1
2025	4	28	16	15	24	0	0	0	0	0	0	0	14.43	0	0	12.8	0.1	1.1
2025	4	28	16	25	24	0	0	0	0	0	0	0	14.41	0	0	12.6	0.1	1.1
2025	4	28	16	35	24	0	0	0	0	0	0	0	14.39	0	0	12.6	0.1	1.1
2025	4	28	16	45	24	0	0	0	0	0	0	0	14.39	0	0	12.6	0.1	1.1
2025	4	28	16	55	24	0	0	0	0	0	0	0	14.37	0	0	12.4	0.1	1.1
2025	4	28	17	5	24	0	0	0	0	0	0	0	14.33	0	0	12.2	0.1	1.1
2025	4	28	17	15	24	0	0	0	0	0	0	0	14.3	0	0	12	0.1	1.1
2025	4	28	17	25	24	0	0	0	0	0	0	0	14.27	0	0	12	0.1	1.1
2025	4	28	17	35	24	0	0	0	0	0	0	0	14.25	0	0	12	0.1	1.1
2025	4	28	17	45	24	0	0	0	0	0	0	0	14.21	0	0	12	0.1	1.1
2025	4	28	17	55	24	0	0	0	0	0	0	0	14.18	0	0	11.8	0.1	1.1
2025	4	28	18	5	24	0	0	0	0	0	0	0	14.14	0	0	11.8	0.1	1.1
2025	4	28	18	15	24	0	0	0	0	0	0	0	14.11	0	0	11.8	0.1	1.1
2025	4	28	18	25	24	0	0	0	0	0	0	0	14.07	0	0	11.8	0.1	1.1
2025	4	28	18	35	24	0	0	0	0	0	0	0	14.03	0	0	11.8	0.1	1.1
2025	4	28	18	45	24	0	0	0	0	0	0	0	14.01	0	0	11.8	0.1	1.1
2025	4	28	18	55	24	0	0	0	0	0	0	0	13.96	0	0	11.8	0.1	1.1
2025	4	28	19	5	24	0	0	0	0	0	0	0	13.93	0	0	11.8	0.1	1.1
2025	4	28	19	15	24	0	0	0	0	0	0	0	13.89	0	0	11.8	0.1	1.1
2025	4	28	19	25	24	0	0	0	0	0	0	0	13.85	0	0	11.8	0.1	1.1
2025	4	28	19	35	24	0	0	0	0	0	0	0	13.81	0	0	11.8	0.1	1.1
2025	4	28	19	45	24	0	0	0	0	0	0	0	13.77	0	0	11.8	0.1	1.1
2025	4	28	19	55	24	0	0	0	0	0	0	0	13.73	0	0	11.8	0.1	1.1
2025	4	28	20	5	24	0	0	0	0	0	0	0	13.69	0	0	11.8	0.1	1.1
2025	4	28	20	15	24	0	0	0	0	0	0	0	13.65	0	0	11.8	0.1	1.1
2025	4	28	20	25	24	0	0	0	0	0	0	0	13.6	0	0	11.8	0.1	1.1
2025	4	28	20	35	24	0	0	0	0	0	0	0	13.55	0	0	11.8	0.1	1.1
2025	4	28	20	45	24	0	0	0	0	0	0	0	13.5	0	0	11.8	0.1	1.1
2025	4	28	20	55	24	0	0	0	0	0	0	0	13.46	0	0	11.8	0.1	1.1
2025	4	28	21	5	24	0	0	0	0	0	0	0	13.41	0	0	11.8	0.1	1.1
2025	4	28	21	15	24	0	0	0	0	0	0	0	13.37	0	0	11.8	0.1	1.1
2025	4	28	21	25	24	0	0	0	0	0	0	0	13.33	0	0	11.8	0.1	1.1
2025	4	28	21	35	24	0	0	0	0	0	0	0	13.28	0	0	11.8	0.1	1.1
2025	4	28	21	45	24	0	0	0	0	0	0	0	13.25	0	0	11.8	0.1	1.1
2025	4	28	21	55	24	0	0	0	0	0	0	0	13.21	0	0	11.8	0.1	1.1
2025	4	28	22	5	24	0	0	0	0	0	0	0	13.18	0	0	11.8	0.1	1.1
2025	4	28	22	15	24	0	0	0	0	0	0	0	13.15	0	0	11.8	0.1	1.1
2025	4	28	22	25	24	0	0	0	0	0	0	0	13.11	0	0	11.8	0.1	1.1
2025	4	28	22	35	24	0	0	0	0	0	0	0	13.08	0	0	11.8	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	28	22	45	24	0	0	0	0	0	0	0	13.05	0	0	11.8	0.1	1.1
2025	4	28	22	55	24	0	0	0	0	0	0	0	13.02	0	0	11.8	0.1	1.1
2025	4	28	23	5	24	0	0	0	0	0	0	0	13	0	0	11.8	0.1	1.1
2025	4	28	23	15	24	0	0	0	0	0	0	0	12.97	0	0	11.6	0.1	1.1
2025	4	28	23	25	24	0	0	0	0	0	0	0	12.94	0	0	11.6	0.1	1.1
2025	4	28	23	35	24	0	0	0	0	0	0	0	12.92	0	0	11.6	0.1	1.1
2025	4	28	23	45	24	0	0	0	0	0	0	0	12.91	0	0	11.6	0.1	1.1
2025	4	28	23	55	24	0	0	0	0	0	0	0	12.89	0	0	11.6	0.1	1.1
2025	4	29	0	5	24	0	0	0	0	0	0	0	12.88	0	0	11.6	0.1	1.1
2025	4	29	0	15	24	0	0	0	0	0	0	0	12.86	0	0	11.6	0.1	1.1
2025	4	29	0	25	24	0	0	0	0	0	0	0	12.85	0	0	11.6	0.1	1.1
2025	4	29	0	35	24	0	0	0	0	0	0	0	12.84	0	0	11.6	0.1	1.1
2025	4	29	0	45	24	0	0	0	0	0	0	0	12.83	0	0	11.6	0.1	1.1
2025	4	29	0	55	24	0	0	0	0	0	0	0	12.82	0	0	11.6	0.1	1.1
2025	4	29	1	5	24	0	0	0	0	0	0	0	12.82	0	0	11.6	0.1	1.1
2025	4	29	1	15	24	0	0	0	0	0	0	0	12.81	0	0	11.6	0.1	1.1
2025	4	29	1	25	24	0	0	0	0	0	0	0	12.81	0	0	11.6	0.1	1.1
2025	4	29	1	35	24	0	0	0	0	0	0	0	12.8	0	0	11.6	0.1	1.1
2025	4	29	1	45	24	0	0	0	0	0	0	0	12.8	0	0	11.6	0.1	1.1
2025	4	29	1	55	24	0	0	0	0	0	0	0	12.81	0	0	11.6	0.1	1.1
2025	4	29	2	5	24	0	0	0	0	0	0	0	12.81	0	0	11.6	0.1	1.1
2025	4	29	2	15	24	0	0	0	0	0	0	0	12.8	0	0	11.6	0.1	1.1
2025	4	29	2	25	24	0	0	0	0	0	0	0	12.81	0	0	11.6	0.1	1.1
2025	4	29	2	35	24	0	0	0	0	0	0	0	12.81	0	0	11.6	0.1	1.1
2025	4	29	2	45	24	0	0	0	0	0	0	0	12.82	0	0	11.6	0.1	1.1
2025	4	29	2	55	24	0	0	0	0	0	0	0	12.82	0	0	11.6	0.1	1.1
2025	4	29	3	5	24	0	0	0	0	0	0	0	12.82	0	0	11.6	0.1	1.1
2025	4	29	3	15	24	0	0	0	0	0	0	0	12.83	0	0	11.6	0.1	1.1
2025	4	29	3	25	24	0	0	0	0	0	0	0	12.83	0	0	11.6	0.1	1.1
2025	4	29	3	35	24	0	0	0	0	0	0	0	12.84	0	0	11.6	0.1	1.1
2025	4	29	3	45	24	0	0	0	0	0	0	0	12.84	0	0	11.6	0.1	1.1
2025	4	29	3	55	24	0	0	0	0	0	0	0	12.85	0	0	11.6	0.1	1.1
2025	4	29	4	5	24	0	0	0	0	0	0	0	12.85	0	0	11.6	0.1	1.1
2025	4	29	4	15	24	0	0	0	0	0	0	0	12.85	0	0	11.6	0.1	1.1
2025	4	29	4	25	24	0	0	0	0	0	0	0	12.85	0	0	11.6	0.1	1.1
2025	4	29	4	35	24	0	0	0	0	0	0	0	12.85	0	0	11.6	0.1	1.1
2025	4	29	4	45	24	0	0	0	0	0	0	0	12.85	0	0	11.6	0.1	1.1
2025	4	29	4	55	24	0	0	0	0	0	0	0	12.85	0	0	11.6	0.1	1.1
2025	4	29	5	5	24	0	0	0	0	0	0	0	12.85	0	0	11.6	0.1	1.1
2025	4	29	5	15	24	0	0	0	0	0	0	0	12.84	0	0	11.6	0.1	1.1
2025	4	29	5	25	24	0	0	0	0	0	0	0	12.84	0	0	11.6	0.1	1.1
2025	4	29	5	35	24	0	0	0	0	0	0	0	12.85	0	0	11.6	0.1	1.1
2025	4	29	5	45	24	0	0	0	0	0	0	0	12.85	0	0	11.6	0.1	1.1
2025	4	29	5	55	24	0	0	0	0	0	0	0	12.85	0	0	11.6	0.1	1.1
2025	4	29	6	5	24	0	0	0	0	0	0	0	12.86	0	0	11.6	0.1	1.1
2025	4	29	6	15	24	0	0	0	0	0	0	0	12.86	0	0	11.6	0.1	1.1
2025	4	29	6	25	24	0	0	0	0	0	0	0	12.87	0	0	11.6	0.1	1.1
2025	4	29	6	35	24	0	0	0	0	0	0	0	12.88	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	29	6	45	24	0	0	0	0	0	0	0	12.89	0	0	11.6	0.1	1.1
2025	4	29	6	55	24	0	0	0	0	0	0	0	12.89	0	0	11.6	0.1	1.1
2025	4	29	7	5	24	0	0	0	0	0	0	0	12.89	0	0	11.8	0.1	1.1
2025	4	29	7	15	24	0	0	0	0	0	0	0	12.91	0	0	11.8	0.1	1.1
2025	4	29	7	25	24	0	0	0	0	0	0	0	12.92	0	0	12	0.1	1.1
2025	4	29	7	35	24	0	0	0	0	0	0	0	12.94	0	0	12.2	0.1	1.1
2025	4	29	7	45	24	0	0	0	0	0	0	0	12.97	0	0	12.4	0.1	1.1
2025	4	29	7	55	24	0	0	0	0	0	0	0	12.99	0	0	12.4	0.1	1.1
2025	4	29	8	5	24	0	0	0	0	0	0	0	13.02	0	0	12.6	0.1	1.1
2025	4	29	8	15	24	0	0	0	0	0	0	0	13.05	0	0	12.6	0.1	1.1
2025	4	29	8	25	24	0	0	0	0	0	0	0	13.09	0	0	12.6	0.1	1.1
2025	4	29	8	35	24	0	0	0	0	0	0	0	13.13	0	0	12.8	0.1	1.1
2025	4	29	8	45	24	0	0	0	0	0	0	0	13.16	0	0	12.8	0.1	1.1
2025	4	29	8	55	24	0	0	0	0	0	0	0	13.21	0	0	12.8	0.1	1.1
2025	4	29	9	5	24	0	0	0	0	0	0	0	13.25	0	0	13	0.1	1.1
2025	4	29	9	15	24	0	0	0	0	0	0	0	13.29	0	0	13	0.1	1.1
2025	4	29	9	25	24	0	0	0	0	0	0	0	13.33	0	0	13.2	0.1	1.1
2025	4	29	9	35	24	0	0	0	0	0	0	0	13.38	0	0	13.2	0.1	1.1
2025	4	29	9	45	24	0	0	0	0	0	0	0	13.42	0	0	13.8	0.1	1.1
2025	4	29	9	55	24	0	0	0	0	0	0	0	13.47	0	0	13.6	0.1	1.1
2025	4	29	10	5	24	0	0	0	0	0	0	0	13.52	0	0	13.8	0.1	1.1
2025	4	29	10	15	24	0	0	0	0	0	0	0	13.57	0	0	13.8	0.1	1.1
2025	4	29	10	25	24	0	0	0	0	0	0	0	13.61	0	0	13.8	0.1	1.1
2025	4	29	10	35	24	0	0	0	0	0	0	0	13.66	0	0	13.8	0.1	1.1
2025	4	29	10	45	24	0	0	0	0	0	0	0	13.71	0	0	13.8	0.1	1.1
2025	4	29	10	55	24	0	0	0	0	0	0	0	13.76	0	0	13.8	0.1	1.1
2025	4	29	11	5	24	0	0	0	0	0	0	0	13.82	0	0	13.8	0.1	1.1
2025	4	29	11	15	24	0	0	0	0	0	0	0	13.87	0	0	13.8	0.1	1.1
2025	4	29	11	25	24	0	0	0	0	0	0	0	13.93	0	0	13.8	0.1	1.1
2025	4	29	11	35	24	0	0	0	0	0	0	0	13.99	0	0	13.6	0.1	1.1
2025	4	29	11	45	24	0	0	0	0	0	0	0	14.03	0	0	13.4	0.1	1.1
2025	4	29	11	55	24	0	0	0	0	0	0	0	14.08	0	0	13.4	0.1	1.1
2025	4	29	12	5	24	0	0	0	0	0	0	0	14.13	0	0	13.4	0.1	1.1
2025	4	29	12	15	24	0	0	0	0	0	0	0	14.17	0	0	13.4	0.1	1.1
2025	4	29	12	25	24	0	0	0	0	0	0	0	14.23	0	0	13.4	0.1	1.1
2025	4	29	12	35	24	0	0	0	0	0	0	0	14.28	0	0	13.4	0.1	1.1
2025	4	29	12	45	24	0	0	0	0	0	0	0	14.32	0	0	13.4	0.1	1.1
2025	4	29	12	55	24	0	0	0	0	0	0	0	14.37	0	0	13.6	0.1	1.1
2025	4	29	13	5	24	0	0	0	0	0	0	0	14.41	0	0	13.6	0.1	1.1
2025	4	29	13	15	24	0	0	0	0	0	0	0	14.45	0	0	13.4	0.1	1.1
2025	4	29	13	25	24	0	0	0	0	0	0	0	14.49	0	0	13.4	0.1	1.1
2025	4	29	13	35	24	0	0	0	0	0	0	0	14.52	0	0	13.4	0.1	1.1
2025	4	29	13	45	24	0	0	0	0	0	0	0	14.56	0	0	13.4	0.1	1.1
2025	4	29	13	55	24	0	0	0	0	0	0	0	14.59	0	0	13.4	0.1	1.1
2025	4	29	14	5	24	0	0	0	0	0	0	0	14.62	0	0	13.6	0.1	1.1
2025	4	29	14	15	24	0	0	0	0	0	0	0	14.65	0	0	13.6	0.1	1.1
2025	4	29	14	25	24	0	0	0	0	0	0	0	14.67	0	0	13.6	0.1	1.1
2025	4	29	14	35	24	0	0	0	0	0	0	0	14.7	0	0	13.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	29	14	45	24	0	0	0	0	0	0	0	14.72	0	0	13.2	0.1	1.1
2025	4	29	14	55	24	0	0	0	0	0	0	0	14.74	0	0	13.2	0.1	1.1
2025	4	29	15	5	24	0	0	0	0	0	0	0	14.76	0	0	13.2	0.1	1.1
2025	4	29	15	15	24	0	0	0	0	0	0	0	14.77	0	0	13.2	0.1	1.1
2025	4	29	15	25	24	0	0	0	0	0	0	0	14.79	0	0	13.2	0.1	1.1
2025	4	29	15	35	24	0	0	0	0	0	0	0	14.79	0	0	13.2	0.1	1.1
2025	4	29	15	45	24	0	0	0	0	0	0	0	14.8	0	0	13.2	0.1	1.1
2025	4	29	15	55	24	0	0	0	0	0	0	0	14.81	0	0	13.2	0.1	1.1
2025	4	29	16	5	24	0	0	0	0	0	0	0	14.81	0	0	13.2	0.1	1.1
2025	4	29	16	15	24	0	0	0	0	0	0	0	14.81	0	0	13.2	0.1	1.1
2025	4	29	16	25	24	0	0	0	0	0	0	0	14.81	0	0	13.2	0.1	1.1
2025	4	29	16	35	24	0	0	0	0	0	0	0	14.81	0	0	13.2	0.1	1.1
2025	4	29	16	45	24	0	0	0	0	0	0	0	14.8	0	0	13.2	0.1	1.1
2025	4	29	16	55	24	0	0	0	0	0	0	0	14.79	0	0	13	0.1	1.1
2025	4	29	17	5	24	0	0	0	0	0	0	0	14.78	0	0	12.6	0.1	1.1
2025	4	29	17	15	24	0	0	0	0	0	0	0	14.77	0	0	12.6	0.1	1.1
2025	4	29	17	25	24	0	0	0	0	0	0	0	14.75	0	0	12.4	0.1	1.1
2025	4	29	17	35	24	0	0	0	0	0	0	0	14.73	0	0	12.2	0.1	1.1
2025	4	29	17	45	24	0	0	0	0	0	0	0	14.7	0	0	12.2	0.1	1.1
2025	4	29	17	55	24	0	0	0	0	0	0	0	14.67	0	0	12	0.1	1.1
2025	4	29	18	5	24	0	0	0	0	0	0	0	14.63	0	0	12	0.1	1.1
2025	4	29	18	15	24	0	0	0	0	0	0	0	14.6	0	0	12	0.1	1.1
2025	4	29	18	25	24	0	0	0	0	0	0	0	14.56	0	0	11.8	0.1	1.1
2025	4	29	18	35	24	0	0	0	0	0	0	0	14.54	0	0	11.8	0.1	1.1
2025	4	29	18	45	24	0	0	0	0	0	0	0	14.5	0	0	11.8	0.1	1.1
2025	4	29	18	55	24	0	0	0	0	0	0	0	14.47	0	0	11.8	0.1	1.1
2025	4	29	19	5	24	0	0	0	0	0	0	0	14.44	0	0	11.8	0.1	1.1
2025	4	29	19	15	24	0	0	0	0	0	0	0	14.4	0	0	11.8	0.1	1.1
2025	4	29	19	25	24	0	0	0	0	0	0	0	14.37	0	0	11.8	0.1	1.1
2025	4	29	19	35	24	0	0	0	0	0	0	0	14.33	0	0	11.8	0.1	1.1
2025	4	29	19	45	24	0	0	0	0	0	0	0	14.29	0	0	11.8	0.1	1.1
2025	4	29	19	55	24	0	0	0	0	0	0	0	14.25	0	0	11.8	0.1	1.1
2025	4	29	20	5	24	0	0	0	0	0	0	0	14.21	0	0	11.8	0.1	1.1
2025	4	29	20	15	24	0	0	0	0	0	0	0	14.18	0	0	11.8	0.1	1.1
2025	4	29	20	25	24	0	0	0	0	0	0	0	14.12	0	0	11.8	0.1	1.1
2025	4	29	20	35	24	0	0	0	0	0	0	0	14.09	0	0	11.8	0.1	1.1
2025	4	29	20	45	24	0	0	0	0	0	0	0	14.04	0	0	11.8	0.1	1.1
2025	4	29	20	55	24	0	0	0	0	0	0	0	14	0	0	11.8	0.1	1.1
2025	4	29	21	5	24	0	0	0	0	0	0	0	13.96	0	0	11.8	0.1	1.1
2025	4	29	21	15	24	0	0	0	0	0	0	0	13.91	0	0	11.8	0.1	1.1
2025	4	29	21	25	24	0	0	0	0	0	0	0	13.87	0	0	11.8	0.1	1.1
2025	4	29	21	35	24	0	0	0	0	0	0	0	13.83	0	0	11.8	0.1	1.1
2025	4	29	21	45	24	0	0	0	0	0	0	0	13.79	0	0	11.8	0.1	1.1
2025	4	29	21	55	24	0	0	0	0	0	0	0	13.76	0	0	11.8	0.1	1.1
2025	4	29	22	5	24	0	0	0	0	0	0	0	13.72	0	0	11.8	0.1	1.1
2025	4	29	22	15	24	0	0	0	0	0	0	0	13.69	0	0	11.8	0.1	1.1
2025	4	29	22	25	24	0	0	0	0	0	0	0	13.65	0	0	11.8	0.1	1.1
2025	4	29	22	35	24	0	0	0	0	0	0	0	13.63	0	0	11.8	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	29	22	45	24	0	0	0	0	0	0	0	13.6	0	0	11.8	0.1	1.1
2025	4	29	22	55	24	0	0	0	0	0	0	0	13.58	0	0	11.8	0.1	1.1
2025	4	29	23	5	24	0	0	0	0	0	0	0	13.56	0	0	11.8	0.1	1.1
2025	4	29	23	15	24	0	0	0	0	0	0	0	13.54	0	0	11.8	0.1	1.1
2025	4	29	23	25	24	0	0	0	0	0	0	0	13.53	0	0	11.8	0.1	1.1
2025	4	29	23	35	24	0	0	0	0	0	0	0	13.51	0	0	11.8	0.1	1.1
2025	4	29	23	45	24	0	0	0	0	0	0	0	13.51	0	0	11.8	0.1	1.1
2025	4	29	23	55	24	0	0	0	0	0	0	0	13.49	0	0	11.6	0.1	1.1
2025	4	30	0	5	24	0	0	0	0	0	0	0	13.48	0	0	11.6	0.1	1.1
2025	4	30	0	15	24	0	0	0	0	0	0	0	13.47	0	0	11.6	0.1	1.1
2025	4	30	0	25	24	0	0	0	0	0	0	0	13.47	0	0	11.6	0.1	1.1
2025	4	30	0	35	24	0	0	0	0	0	0	0	13.45	0	0	11.6	0.1	1.1
2025	4	30	0	45	24	0	0	0	0	0	0	0	13.45	0	0	11.6	0.1	1.1
2025	4	30	0	55	24	0	0	0	0	0	0	0	13.45	0	0	11.6	0.1	1.1
2025	4	30	1	5	24	0	0	0	0	0	0	0	13.44	0	0	11.6	0.1	1.1
2025	4	30	1	15	24	0	0	0	0	0	0	0	13.43	0	0	11.6	0.1	1.1
2025	4	30	1	25	24	0	0	0	0	0	0	0	13.44	0	0	11.6	0.1	1.1
2025	4	30	1	35	24	0	0	0	0	0	0	0	13.44	0	0	11.6	0.1	1.1
2025	4	30	1	45	24	0	0	0	0	0	0	0	13.44	0	0	11.6	0.1	1.1
2025	4	30	1	55	24	0	0	0	0	0	0	0	13.45	0	0	11.6	0.1	1.1
2025	4	30	2	5	24	0	0	0	0	0	0	0	13.46	0	0	11.6	0.1	1.1
2025	4	30	2	15	24	0	0	0	0	0	0	0	13.46	0	0	11.6	0.1	1.1
2025	4	30	2	25	24	0	0	0	0	0	0	0	13.47	0	0	11.6	0.1	1.1
2025	4	30	2	35	24	0	0	0	0	0	0	0	13.48	0	0	11.6	0.1	1.1
2025	4	30	2	45	24	0	0	0	0	0	0	0	13.49	0	0	11.6	0.1	1.1
2025	4	30	2	55	24	0	0	0	0	0	0	0	13.5	0	0	11.6	0.1	1.1
2025	4	30	3	5	24	0	0	0	0	0	0	0	13.51	0	0	11.6	0.1	1.1
2025	4	30	3	15	24	0	0	0	0	0	0	0	13.53	0	0	11.6	0.1	1.1
2025	4	30	3	25	24	0	0	0	0	0	0	0	13.53	0	0	11.6	0.1	1.1
2025	4	30	3	35	24	0	0	0	0	0	0	0	13.55	0	0	11.6	0.1	1.1
2025	4	30	3	45	24	0	0	0	0	0	0	0	13.57	0	0	11.6	0.1	1.1
2025	4	30	3	55	24	0	0	0	0	0	0	0	13.59	0	0	11.6	0.1	1.1
2025	4	30	4	5	24	0	0	0	0	0	0	0	13.6	0	0	11.6	0.1	1.1
2025	4	30	4	15	24	0	0	0	0	0	0	0	13.63	0	0	11.6	0.1	1.1
2025	4	30	4	25	24	0	0	0	0	0	0	0	13.65	0	0	11.6	0.1	1.1
2025	4	30	4	35	24	0	0	0	0	0	0	0	13.67	0	0	11.6	0.1	1.1
2025	4	30	4	45	24	0	0	0	0	0	0	0	13.69	0	0	11.6	0.1	1.1
2025	4	30	4	55	24	0	0	0	0	0	0	0	13.72	0	0	11.6	0.1	1.1
2025	4	30	5	5	24	0	0	0	0	0	0	0	13.74	0	0	11.6	0.1	1.1
2025	4	30	5	15	24	0	0	0	0	0	0	0	13.77	0	0	11.6	0.1	1.1
2025	4	30	5	25	24	0	0	0	0	0	0	0	13.78	0	0	11.6	0.1	1.1
2025	4	30	5	35	24	0	0	0	0	0	0	0	13.8	0	0	11.6	0.1	1.1
2025	4	30	5	45	24	0	0	0	0	0	0	0	13.82	0	0	11.6	0.1	1.1
2025	4	30	5	55	24	0	0	0	0	0	0	0	13.84	0	0	11.6	0.1	1.1
2025	4	30	6	5	24	0	0	0	0	0	0	0	13.86	0	0	11.6	0.1	1.1
2025	4	30	6	15	24	0	0	0	0	0	0	0	13.87	0	0	11.6	0.1	1.1
2025	4	30	6	25	24	0	0	0	0	0	0	0	13.89	0	0	11.6	0.1	1.1
2025	4	30	6	35	24	0	0	0	0	0	0	0	13.91	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	30	6	45	24	0	0	0	0	0	0	0	13.92	0	0	11.6	0.1	1.1
2025	4	30	6	55	24	0	0	0	0	0	0	0	13.95	0	0	11.6	0.1	1.1
2025	4	30	7	5	24	0	0	0	0	0	0	0	13.97	0	0	11.8	0.1	1.1
2025	4	30	7	15	24	0	0	0	0	0	0	0	13.99	0	0	11.8	0.1	1.1
2025	4	30	7	25	24	0	0	0	0	0	0	0	14.02	0	0	12	0.1	1.1
2025	4	30	7	35	24	0	0	0	0	0	0	0	14.04	0	0	11.8	0.1	1.1
2025	4	30	7	45	24	0	0	0	0	0	0	0	14.08	0	0	12	0.1	1.1
2025	4	30	7	55	24	0	0	0	0	0	0	0	14.12	0	0	12.4	0.1	1.1
2025	4	30	8	5	24	0	0	0	0	0	0	0	14.16	0	0	12.6	0.1	1.1
2025	4	30	8	15	24	0	0	0	0	0	0	0	14.19	0	0	12.6	0.1	1.1
2025	4	30	8	25	24	0	0	0	0	0	0	0	14.24	0	0	12.6	0.1	1.1
2025	4	30	8	35	24	0	0	0	0	0	0	0	14.29	0	0	12.8	0.1	1.1
2025	4	30	8	45	24	0	0	0	0	0	0	0	14.35	0	0	12.8	0.1	1.1
2025	4	30	8	55	24	0	0	0	0	0	0	0	14.39	0	0	12.8	0.1	1.1
2025	4	30	9	5	24	0	0	0	0	0	0	0	14.45	0	0	13	0.1	1.1
2025	4	30	9	15	24	0	0	0	0	0	0	0	14.5	0	0	12.8	0.1	1.1
2025	4	30	9	25	24	0	0	0	0	0	0	0	14.53	0	0	12.8	0.1	1.1
2025	4	30	9	35	24	0	0	0	0	0	0	0	14.56	0	0	12.8	0.1	1.1
2025	4	30	9	45	24	0	0	0	0	0	0	0	14.6	0	0	12.8	0.1	1.1
2025	4	30	9	55	24	0	0	0	0	0	0	0	14.65	0	0	13	0.1	1.1
2025	4	30	10	5	24	0	0	0	0	0	0	0	14.68	0	0	13.2	0.1	1.1
2025	4	30	10	15	24	0	0	0	0	0	0	0	14.75	0	0	13.4	0.1	1.1
2025	4	30	10	25	24	0	0	0	0	0	0	0	14.83	0	0	13.4	0.1	1.1
2025	4	30	10	35	24	0	0	0	0	0	0	0	14.86	0	0	13.4	0.1	1.1
2025	4	30	10	45	24	0	0	0	0	0	0	0	14.88	0	0	13.4	0.1	1.1
2025	4	30	10	55	24	0	0	0	0	0	0	0	14.91	0	0	13.4	0.1	1.1
2025	4	30	11	5	24	0	0	0	0	0	0	0	14.94	0	0	13.4	0.1	1.1
2025	4	30	11	15	24	0	0	0	0	0	0	0	14.98	0	0	13.4	0.1	1.1
2025	4	30	11	25	24	0	0	0	0	0	0	0	15.03	0	0	13.4	0.1	1.1
2025	4	30	11	35	24	0	0	0	0	0	0	0	15.05	0	0	13.4	0.1	1.1
2025	4	30	11	45	24	0	0	0	0	0	0	0	15.1	0	0	13.4	0.1	1.1
2025	4	30	11	55	24	0	0	0	0	0	0	0	15.14	0	0	13.4	0.1	1.1
2025	4	30	12	5	24	0	0	0	0	0	0	0	15.16	0	0	13.4	0.1	1.1
2025	4	30	12	15	24	0	0	0	0	0	0	0	15.2	0	0	13.4	0.1	1.1
2025	4	30	12	25	24	0	0	0	0	0	0	0	15.23	0	0	13.2	0.1	1.1
2025	4	30	12	35	24	0	0	0	0	0	0	0	15.31	0	0	13.4	0.1	1.1
2025	4	30	12	45	24	0	0	0	0	0	0	0	15.37	0	0	13.4	0.1	1.1
2025	4	30	12	55	24	0	0	0	0	0	0	0	15.46	0	0	13.2	0.1	1.1
2025	4	30	13	5	24	0	0	0	0	0	0	0	15.54	0	0	13.2	0.1	1.1
2025	4	30	13	15	24	0	0	0	0	0	0	0	15.62	0	0	13.2	0.1	1.1
2025	4	30	13	25	24	0	0	0	0	0	0	0	15.68	0	0	13.2	0.1	1.1
2025	4	30	13	35	24	0	0	0	0	0	0	0	15.64	0	0	12.8	0.1	1.1
2025	4	30	13	45	24	0	0	0	0	0	0	0	15.6	0	0	12.6	0.1	1.1
2025	4	30	13	55	24	0	0	0	0	0	0	0	15.57	0	0	12.2	0.1	1.1
2025	4	30	14	5	24	0	0	0	0	0	0	0	15.53	0	0	12	0.1	1.1
2025	4	30	14	15	24	0	0	0	0	0	0	0	15.5	0	0	12	0.1	1.1
2025	4	30	14	25	24	0	0	0	0	0	0	0	15.48	0	0	12	0.1	1.1
2025	4	30	14	35	24	0	0	0	0	0	0	0	15.47	0	0	12.2	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	30	14	45	24	0	0	0	0	0	0	0	15.51	0	0	13.4	0.1	1.1
2025	4	30	14	55	24	0	0	0	0	0	0	0	15.52	0	0	13.2	0.1	1.1
2025	4	30	15	5	24	0	0	0	0	0	0	0	15.51	0	0	12.6	0.1	1.1
2025	4	30	15	15	24	0	0	0	0	0	0	0	15.5	0	0	12.2	0.1	1.1
2025	4	30	15	25	24	0	0	0	0	0	0	0	15.48	0	0	12	0.1	1.1
2025	4	30	15	35	24	0	0	0	0	0	0	0	15.47	0	0	12	0.1	1.1
2025	4	30	15	45	24	0	0	0	0	0	0	0	15.45	0	0	12	0.1	1.1
2025	4	30	15	55	24	0	0	0	0	0	0	0	15.43	0	0	12	0.1	1.1
2025	4	30	16	5	24	0	0	0	0	0	0	0	15.41	0	0	12	0.1	1.1
2025	4	30	16	15	24	0	0	0	0	0	0	0	15.38	0	0	12	0.1	1.1
2025	4	30	16	25	24	0	0	0	0	0	0	0	15.36	0	0	12	0.1	1.1
2025	4	30	16	35	24	0	0	0	0	0	0	0	15.33	0	0	11.8	0.1	1.1
2025	4	30	16	45	24	0	0	0	0	0	0	0	15.3	0	0	11.8	0.1	1.1
2025	4	30	16	55	24	0	0	0	0	0	0	0	15.27	0	0	11.8	0.1	1.1
2025	4	30	17	5	24	0	0	0	0	0	0	0	15.24	0	0	11.8	0.1	1.1
2025	4	30	17	15	24	0	0	0	0	0	0	0	15.21	0	0	11.8	0.1	1.1
2025	4	30	17	25	24	0	0	0	0	0	0	0	15.17	0	0	11.8	0.1	1.1
2025	4	30	17	35	24	0	0	0	0	0	0	0	15.14	0	0	11.8	0.1	1.1
2025	4	30	17	45	24	0	0	0	0	0	0	0	15.1	0	0	11.8	0.1	1.1
2025	4	30	17	55	24	0	0	0	0	0	0	0	15.06	0	0	11.8	0.1	1.1
2025	4	30	18	5	24	0	0	0	0	0	0	0	15.03	0	0	11.8	0.1	1.1
2025	4	30	18	15	24	0	0	0	0	0	0	0	14.99	0	0	11.8	0.1	1.1
2025	4	30	18	25	24	0	0	0	0	0	0	0	14.96	0	0	11.8	0.1	1.1
2025	4	30	18	35	24	0	0	0	0	0	0	0	14.91	0	0	11.8	0.1	1.1
2025	4	30	18	45	24	0	0	0	0	0	0	0	14.88	0	0	11.8	0.1	1.1
2025	4	30	18	55	24	0	0	0	0	0	0	0	14.83	0	0	11.8	0.1	1.1
2025	4	30	19	5	24	0	0	0	0	0	0	0	14.79	0	0	11.8	0.1	1.1
2025	4	30	19	15	24	0	0	0	0	0	0	0	14.75	0	0	11.8	0.1	1.1
2025	4	30	19	25	24	0	0	0	0	0	0	0	14.7	0	0	11.8	0.1	1.1
2025	4	30	19	35	24	0	0	0	0	0	0	0	14.65	0	0	11.8	0.1	1.1
2025	4	30	19	45	24	0	0	0	0	0	0	0	14.6	0	0	11.8	0.1	1.1
2025	4	30	19	55	24	0	0	0	0	0	0	0	14.56	0	0	11.8	0.1	1.1
2025	4	30	20	5	24	0	0	0	0	0	0	0	14.52	0	0	11.8	0.1	1.1
2025	4	30	20	15	24	0	0	0	0	0	0	0	14.48	0	0	11.8	0.1	1.1
2025	4	30	20	25	24	0	0	0	0	0	0	0	14.44	0	0	11.8	0.1	1.1
2025	4	30	20	35	24	0	0	0	0	0	0	0	14.41	0	0	11.6	0.1	1.1
2025	4	30	20	45	24	0	0	0	0	0	0	0	14.38	0	0	11.6	0.1	1.1
2025	4	30	20	55	24	0	0	0	0	0	0	0	14.33	0	0	11.6	0.1	1.1
2025	4	30	21	5	24	0	0	0	0	0	0	0	14.29	0	0	11.6	0.1	1.1
2025	4	30	21	15	24	0	0	0	0	0	0	0	14.26	0	0	11.6	0.1	1.1
2025	4	30	21	25	24	0	0	0	0	0	0	0	14.23	0	0	11.6	0.1	1.1
2025	4	30	21	35	24	0	0	0	0	0	0	0	14.19	0	0	11.6	0.1	1.1
2025	4	30	21	45	24	0	0	0	0	0	0	0	14.17	0	0	11.6	0.1	1.1
2025	4	30	21	55	24	0	0	0	0	0	0	0	14.15	0	0	11.6	0.1	1.1
2025	4	30	22	5	24	0	0	0	0	0	0	0	14.12	0	0	11.6	0.1	1.1
2025	4	30	22	15	24	0	0	0	0	0	0	0	14.1	0	0	11.6	0.1	1.1
2025	4	30	22	25	24	0	0	0	0	0	0	0	14.07	0	0	11.6	0.1	1.1
2025	4	30	22	35	24	0	0	0	0	0	0	0	14.06	0	0	11.6	0.1	1.1

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	4	30	22	45	24	0	0	0	0	0	0	0	14.04	0	0	11.6	0.1	1.1
2025	4	30	22	55	24	0	0	0	0	0	0	0	14.02	0	0	11.6	0.1	1.1
2025	4	30	23	5	24	0	0	0	0	0	0	0	14.01	0	0	11.6	0.1	1.1
2025	4	30	23	15	24	0	0	0	0	0	0	0	14	0	0	11.6	0.1	1.1
2025	4	30	23	25	24	0	0	0	0	0	0	0	13.99	0	0	11.6	0.1	1.1
2025	4	30	23	35	24	0	0	0	0	0	0	0	13.98	0	0	11.6	0.1	1.1
2025	4	30	23	45	24	0	0	0	0	0	0	0	13.97	0	0	11.6	0.1	1.1
2025	4	30	23	55	24	0	0	0	0	0	0	0	13.96	0	0	11.6	0.1	1.1

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	1	0	2	55	0.69	98.8	75.8137	48.7616
2025	4	1	0	12	55	0.73	99.9	75.8137	51.3528
2025	4	1	0	22	55	0.67	97.6	75.8137	47.5838
2025	4	1	0	32	55	0.66	96	75.8137	46.8772
2025	4	1	0	42	55	0.7	96.7	75.8137	50.1751
2025	4	1	0	52	55	0.67	95.9	75.8137	48.055
2025	4	1	1	2	55	0.68	98.1	75.8137	48.055
2025	4	1	1	12	55	0.72	97.8	75.748	51.3064
2025	4	1	1	22	55	0.68	97.2	75.748	48.4823
2025	4	1	1	32	55	0.68	99.5	75.748	48.0116
2025	4	1	1	42	55	0.7	93.5	75.748	49.8944
2025	4	1	1	52	55	0.73	97	75.8137	52.0597
2025	4	1	2	2	55	0.68	99.5	75.8137	48.0551
2025	4	1	2	12	55	0.69	100.7	75.8137	48.7619
2025	4	1	2	22	55	0.69	97.7	75.8137	48.7619
2025	4	1	2	32	55	0.68	97.2	75.8137	48.5263
2025	4	1	2	42	55	0.69	98.5	75.8137	48.7619
2025	4	1	2	52	55	0.67	99.8	75.8137	47.5841
2025	4	1	3	2	55	0.69	97.7	75.8137	48.9975
2025	4	1	3	12	55	0.7	99.2	75.8137	49.7042
2025	4	1	3	22	55	0.68	96.9	75.8137	48.762
2025	4	1	3	32	55	0.66	96.8	75.8137	47.3486
2025	4	1	3	42	55	0.76	97.4	75.8137	54.4156
2025	4	1	3	52	55	0.68	98.8	75.8137	48.5265
2025	4	1	4	2	55	0.73	97.4	75.8137	52.2955
2025	4	1	4	12	55	0.72	100.5	75.8137	50.6466
2025	4	1	4	22	55	0.71	98.2	75.8137	50.411
2025	4	1	4	32	55	0.65	98.7	75.8137	45.9353
2025	4	1	4	42	55	0.69	98.8	75.8137	48.7621
2025	4	1	4	52	55	0.66	98	75.8137	46.6421
2025	4	1	5	2	55	0.69	99.6	75.8137	48.5266
2025	4	1	5	12	55	0.71	98.5	75.8137	50.6467
2025	4	1	5	22	55	0.68	97.5	75.8137	48.5267
2025	4	1	5	32	55	0.7	98.4	75.8137	49.4689
2025	4	1	5	42	55	0.66	96	75.8137	46.8777
2025	4	1	5	52	55	0.7	99.8	75.8137	49.2334
2025	4	1	6	2	55	0.7	99.4	75.748	49.6596
2025	4	1	6	12	55	0.73	98.5	75.748	52.0131
2025	4	1	6	22	55	0.69	96	75.748	48.9535
2025	4	1	6	32	55	0.68	97.5	75.748	48.2475
2025	4	1	6	42	55	0.71	97.2	75.748	50.3657
2025	4	1	6	52	55	0.73	96.2	75.748	52.2486
2025	4	1	7	2	55	0.66	96.2	75.748	47.3061
2025	4	1	7	12	55	0.73	98	75.748	52.0132
2025	4	1	7	22	55	0.72	97.9	75.748	50.8364
2025	4	1	7	32	55	0.71	96.4	75.748	50.3657
2025	4	1	7	42	55	0.71	96.7	75.748	50.3657
2025	4	1	7	52	55	0.72	97.6	75.748	51.0717

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	1	8	2	55	0.68	97.5	75.748	48.2475
2025	4	1	8	12	55	0.66	100.5	75.748	46.8353
2025	4	1	8	22	55	0.71	100.6	75.748	50.3656
2025	4	1	8	32	55	0.69	97.9	75.748	49.1888
2025	4	1	8	42	55	0.71	98.7	75.748	50.6009
2025	4	1	8	52	55	0.71	98.8	75.8137	50.1756
2025	4	1	9	2	55	0.72	97.8	75.8137	51.3534
2025	4	1	9	12	55	0.67	98.4	75.8137	47.8199
2025	4	1	9	22	55	0.69	96.8	75.8137	49.4688
2025	4	1	9	32	55	0.7	98.4	75.8137	49.7044
2025	4	1	9	42	55	0.72	97.1	75.8137	51.3533
2025	4	1	9	52	55	0.63	93.9	75.748	45.1876
2025	4	1	10	2	55	0.65	101.4	75.8137	45.6997
2025	4	1	10	12	55	0.69	100.1	75.8137	48.762
2025	4	1	10	22	55	0.7	97.6	75.8137	49.4686
2025	4	1	10	32	55	0.68	99.4	75.8137	48.5264
2025	4	1	10	42	55	0.72	98.1	75.8137	51.1175
2025	4	1	10	52	55	0.68	98.3	75.8137	48.2907
2025	4	1	11	2	55	0.66	98.5	75.8137	47.1129
2025	4	1	11	12	55	0.68	97.4	75.8137	48.7618
2025	4	1	11	22	55	0.67	96.2	75.8137	47.584
2025	4	1	11	32	55	0.7	96.2	75.8137	50.1751
2025	4	1	11	42	55	0.71	98.8	75.8137	50.1752
2025	4	1	11	52	55	0.69	97.4	75.8137	49.2329
2025	4	1	12	2	55	0.7	99.1	75.8137	49.9396
2025	4	1	12	12	55	0.7	95.9	75.8137	49.9395
2025	4	1	12	22	55	0.73	98.5	75.8793	52.1067
2025	4	1	12	32	55	0.66	96.8	75.8793	47.3911
2025	4	1	12	42	55	0.72	98.2	75.8793	50.9278
2025	4	1	12	52	55	0.7	97.8	75.8793	49.7489
2025	4	1	13	2	55	0.71	99.6	75.8137	49.9394
2025	4	1	13	12	55	0.71	99.9	75.8793	50.2203
2025	4	1	13	22	55	0.68	98.1	75.8793	48.0983
2025	4	1	13	32	55	0.69	97.7	75.8793	48.8056
2025	4	1	13	42	55	0.7	98.8	75.8793	49.9845
2025	4	1	13	52	55	0.7	97.2	75.8793	50.2202
2025	4	1	14	2	55	0.67	98.2	75.8137	47.348
2025	4	1	14	12	55	0.69	96.8	75.8793	49.5129
2025	4	1	14	22	55	0.72	95.2	75.8137	51.3525
2025	4	1	14	32	55	0.69	95.7	75.8793	49.5128
2025	4	1	14	42	55	0.7	98.3	75.8793	49.9844
2025	4	1	14	52	55	0.7	99.5	75.8793	49.2771
2025	4	1	15	2	55	0.71	96.1	75.8793	50.6917
2025	4	1	15	12	55	0.7	95.4	75.8793	49.9844
2025	4	1	15	22	55	0.71	98.3	75.8793	50.2202
2025	4	1	15	32	55	0.68	99.7	75.8793	48.0982
2025	4	1	15	42	55	0.65	97.8	75.8793	46.212
2025	4	1	15	52	55	0.71	96.4	75.8793	50.4559

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	1	16	2	55	0.7	98.1	75.8137	49.4681
2025	4	1	16	12	55	0.7	97.2	75.8793	50.2202
2025	4	1	16	22	55	0.69	97.4	75.8793	49.2771
2025	4	1	16	32	55	0.69	97.7	75.8793	48.8056
2025	4	1	16	42	55	0.69	100.9	75.8793	48.8056
2025	4	1	16	52	55	0.68	98.6	75.8793	48.0983
2025	4	1	17	2	55	0.69	97.9	75.8793	49.2772
2025	4	1	17	12	55	0.7	97.3	75.8793	49.9845
2025	4	1	17	22	55	0.69	96.3	75.8793	49.2772
2025	4	1	17	32	55	0.67	97.3	75.8793	48.0983
2025	4	1	17	42	55	0.69	97.4	75.8793	49.2772
2025	4	1	17	52	55	0.69	98.2	75.8793	48.8057
2025	4	1	18	2	55	0.67	96.5	75.8793	47.6268
2025	4	1	18	12	55	0.7	96.5	75.8793	49.7488
2025	4	1	18	22	55	0.73	97.2	75.8137	52.295
2025	4	1	18	32	55	0.71	97.2	75.8793	50.6919
2025	4	1	18	42	55	0.68	94.9	75.8793	49.0415
2025	4	1	18	52	55	0.71	96.9	75.8793	50.4562
2025	4	1	19	2	55	0.67	97.1	75.8137	47.5838
2025	4	1	19	12	55	0.69	97.4	75.8793	49.0416
2025	4	1	19	22	55	0.66	98.6	75.8793	46.9196
2025	4	1	19	32	55	0.67	95.9	75.8793	48.0985
2025	4	1	19	42	55	0.63	94.1	75.8137	45.4638
2025	4	1	19	52	55	0.71	97.9	75.8793	50.6921
2025	4	1	20	2	55	0.72	98.9	75.8793	50.9279
2025	4	1	20	12	55	0.66	101.8	75.8793	46.2124
2025	4	1	20	22	55	0.66	97.7	75.8793	46.9198
2025	4	1	20	32	55	0.68	98.6	75.8137	48.5263
2025	4	1	20	42	55	0.69	98.2	75.8793	48.8061
2025	4	1	20	52	55	0.69	96	75.8137	48.9975
2025	4	1	21	2	55	0.69	96	75.8137	49.2331
2025	4	1	21	12	55	0.7	98.1	75.8137	49.4687
2025	4	1	21	22	55	0.67	100.2	75.8137	47.3487
2025	4	1	21	32	55	0.68	98.6	75.8137	48.5265
2025	4	1	21	42	55	0.68	100.5	75.8137	48.291
2025	4	1	21	52	55	0.66	98	75.8137	47.1132
2025	4	1	22	2	55	0.66	99.2	75.8137	46.6421
2025	4	1	22	12	55	0.73	98.6	75.8137	51.589
2025	4	1	22	22	55	0.67	98.2	75.8137	47.5844
2025	4	1	22	32	55	0.7	97.2	75.8137	50.1757
2025	4	1	22	42	55	0.69	97.1	75.8137	49.2335
2025	4	1	22	52	55	0.71	97.2	75.8137	50.6469
2025	4	1	23	2	55	0.67	98.5	75.748	47.3061
2025	4	1	23	12	55	0.67	97.3	75.748	48.0122
2025	4	1	23	22	55	0.72	98.2	75.748	50.8365
2025	4	1	23	32	55	0.67	97.9	75.748	47.3062
2025	4	1	23	42	55	0.67	98.7	75.748	47.5416
2025	4	1	23	52	55	0.69	99.3	75.748	48.7184

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	2	0	2	55	0.7	96.2	75.748	49.6599
2025	4	2	0	12	55	0.7	98.4	75.748	49.6599
2025	4	2	0	22	55	0.68	97.4	75.748	48.7185
2025	4	2	0	32	55	0.66	98	75.748	46.8357
2025	4	2	0	42	55	0.74	97.6	75.748	52.7196
2025	4	2	0	52	55	0.76	96.2	75.748	54.1317
2025	4	2	1	2	55	0.63	95.7	75.748	45.1883
2025	4	2	1	12	55	0.73	98.8	75.748	51.7782
2025	4	2	1	22	55	0.71	98.5	75.748	50.1308
2025	4	2	1	32	55	0.69	99.6	75.6824	48.4394
2025	4	2	1	42	55	0.72	98.4	75.748	51.3076
2025	4	2	1	52	55	0.68	98.3	75.748	48.4833
2025	4	2	2	2	55	0.69	100.1	75.6824	48.6745
2025	4	2	2	12	55	0.74	99	75.748	52.2491
2025	4	2	2	22	55	0.7	98.4	75.6824	49.38
2025	4	2	2	32	55	0.66	97.7	75.6824	47.0286
2025	4	2	2	42	55	0.73	96.5	75.6824	51.9666
2025	4	2	2	52	55	0.7	96.7	75.6824	49.8503
2025	4	2	3	2	55	0.68	96.1	75.6824	48.6746
2025	4	2	3	12	55	0.64	95.3	75.6824	45.8529
2025	4	2	3	22	55	0.7	96.2	75.6824	49.8503
2025	4	2	3	32	55	0.7	98.4	75.6824	49.3801
2025	4	2	3	42	55	0.68	97.8	75.6824	47.9692
2025	4	2	3	52	55	0.7	95.9	75.6824	49.8504
2025	4	2	4	2	55	0.65	97.2	75.6824	46.5584
2025	4	2	4	12	55	0.69	96.3	75.6824	48.9098
2025	4	2	4	22	55	0.65	99.7	75.6824	45.6178
2025	4	2	4	32	55	0.67	97.3	75.6824	47.7341
2025	4	2	4	42	55	0.68	98.1	75.6824	48.2044
2025	4	2	4	52	55	0.69	95.8	75.6824	48.9098
2025	4	2	5	2	55	0.71	94.5	75.6168	50.7449
2025	4	2	5	12	55	0.69	98.4	75.6824	49.145
2025	4	2	5	22	55	0.66	97.4	75.6824	47.2638
2025	4	2	5	32	55	0.65	95.8	75.6824	46.5584
2025	4	2	5	42	55	0.69	98	75.6824	48.6747
2025	4	2	5	52	55	0.68	95	75.6824	48.6747
2025	4	2	6	2	55	0.68	97.8	75.6824	47.9692
2025	4	2	6	12	55	0.63	96.5	75.6824	45.1475
2025	4	2	6	22	55	0.71	96.3	75.6824	50.7909
2025	4	2	6	32	55	0.74	96.9	75.6824	52.6721
2025	4	2	6	42	55	0.66	97.5	75.6824	46.5584
2025	4	2	6	52	55	0.67	99.8	75.6824	47.4989
2025	4	2	7	2	55	0.68	97.4	75.6824	48.6746
2025	4	2	7	12	55	0.65	95.5	75.6168	46.2811
2025	4	2	7	22	55	0.71	97.8	75.6168	50.04
2025	4	2	7	32	55	0.68	98.1	75.6824	48.2043
2025	4	2	7	42	55	0.69	95.2	75.6168	48.8653
2025	4	2	7	52	55	0.72	98.9	75.6824	51.0259

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	2	8	2	55	0.71	96.4	75.6168	50.5097
2025	4	2	8	12	55	0.68	100.6	75.6168	47.9255
2025	4	2	8	22	55	0.69	97.1	75.6168	49.1001
2025	4	2	8	32	55	0.69	96	75.6824	48.9095
2025	4	2	8	42	55	0.7	97.9	75.6168	49.335
2025	4	2	8	52	55	0.68	99.8	75.6168	47.6904
2025	4	2	9	2	55	0.67	96.7	75.6824	47.9688
2025	4	2	9	12	55	0.69	98.2	75.6824	49.1445
2025	4	2	9	22	55	0.67	99.2	75.6168	47.6903
2025	4	2	9	32	55	0.69	96.5	75.6168	49.3348
2025	4	2	9	42	55	0.67	97	75.6824	47.7336
2025	4	2	9	52	55	0.69	97.9	75.6824	49.1444
2025	4	2	10	2	55	0.7	98.1	75.6824	49.6146
2025	4	2	10	12	55	0.68	97.4	75.6168	48.6298
2025	4	2	10	22	55	0.67	97.7	75.6824	47.2631
2025	4	2	10	32	55	0.68	98.9	75.6824	47.9685
2025	4	2	10	42	55	0.7	98.6	75.6168	49.8043
2025	4	2	10	52	55	0.68	98.9	75.6824	47.9684
2025	4	2	11	2	55	0.66	94.3	75.6824	47.0278
2025	4	2	11	12	55	0.69	97.7	75.6168	48.8645
2025	4	2	11	22	55	0.65	96.9	75.6824	46.5575
2025	4	2	11	32	55	0.69	100.4	75.6824	48.6737
2025	4	2	11	42	55	0.69	97.9	75.6824	49.144
2025	4	2	11	52	55	0.65	97.6	75.6824	46.0872
2025	4	2	12	2	55	0.7	99.7	75.6824	49.3791
2025	4	2	12	12	55	0.68	95.8	75.6824	48.6736
2025	4	2	12	22	55	0.66	97.7	75.6824	46.7925
2025	4	2	12	32	55	0.72	97.5	75.6824	51.4953
2025	4	2	12	42	55	0.7	97.3	75.6824	49.8493
2025	4	2	12	52	55	0.68	98.8	75.6168	48.3946
2025	4	2	13	2	55	0.74	98.4	75.6824	52.4358
2025	4	2	13	12	55	0.66	97.7	75.6824	47.0275
2025	4	2	13	22	55	0.69	96.6	75.6168	49.0992
2025	4	2	13	32	55	0.66	97.8	75.6824	46.5573
2025	4	2	13	42	55	0.69	96	75.6168	48.8643
2025	4	2	13	52	55	0.67	97.7	75.6824	47.2626
2025	4	2	14	2	55	0.66	96.8	75.6824	47.2625
2025	4	2	14	12	55	0.69	97.9	75.6168	48.8642
2025	4	2	14	22	55	0.7	95.4	75.6168	49.8038
2025	4	2	14	32	55	0.71	95.6	75.6168	50.2736
2025	4	2	14	42	55	0.69	98.7	75.5512	48.8198
2025	4	2	14	52	55	0.68	98.1	75.5512	47.8809
2025	4	2	15	2	55	0.69	96.6	75.5512	48.8198
2025	4	2	15	12	55	0.67	94.5	75.4856	47.8374
2025	4	2	15	22	55	0.7	95.7	75.4856	49.7134
2025	4	2	15	32	55	0.7	99.7	75.4856	49.2444
2025	4	2	15	42	55	0.72	98.4	75.4856	50.8859
2025	4	2	15	52	55	0.7	95.9	75.5512	49.7587

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	2	16	2	55	0.71	96.1	75.5512	50.4628
2025	4	2	16	12	55	0.66	97.4	75.4856	46.665
2025	4	2	16	22	55	0.67	94.7	75.4856	48.0719
2025	4	2	16	32	55	0.73	98.1	75.4856	51.3549
2025	4	2	16	42	55	0.71	99.6	75.4856	49.7134
2025	4	2	16	52	55	0.72	98.4	75.4856	50.6514
2025	4	2	17	2	55	0.7	96.7	75.4856	49.9479
2025	4	2	17	12	55	0.7	98.1	75.4856	49.7134
2025	4	2	17	22	55	0.69	97.9	75.4856	48.7754
2025	4	2	17	32	55	0.66	96	75.4856	47.134
2025	4	2	17	42	55	0.7	98.3	75.4856	49.7135
2025	4	2	17	52	55	0.69	97.7	75.4856	48.7755
2025	4	2	18	2	55	0.69	97.1	75.4856	49.01
2025	4	2	18	12	55	0.69	97.4	75.42	48.9654
2025	4	2	18	22	55	0.68	98.6	75.42	47.794
2025	4	2	18	32	55	0.7	96.5	75.42	49.434
2025	4	2	18	42	55	0.71	95.6	75.42	50.1369
2025	4	2	18	52	55	0.68	99.1	75.3543	47.9847
2025	4	2	19	2	55	0.71	96.6	75.42	50.3713
2025	4	2	19	12	55	0.64	96.8	75.42	45.4513
2025	4	2	19	22	55	0.7	96.7	75.42	49.6685
2025	4	2	19	32	55	0.64	97.9	75.42	45.4514
2025	4	2	19	42	55	0.68	95.3	75.4856	48.3068
2025	4	2	19	52	55	0.68	97.5	75.4856	48.0723
2025	4	2	20	2	55	0.7	98.1	75.4856	49.2448
2025	4	2	20	12	55	0.71	97.2	75.42	50.3715
2025	4	2	20	22	55	0.7	98.6	75.42	49.4344
2025	4	2	20	32	55	0.74	95.6	75.42	52.2459
2025	4	2	20	42	55	0.66	98.5	75.42	46.8573
2025	4	2	20	52	55	0.73	98.8	75.42	51.5431
2025	4	2	21	2	55	0.68	98.3	75.4856	48.0725
2025	4	2	21	12	55	0.66	97.4	75.4856	46.6656
2025	4	2	21	22	55	0.69	97.4	75.5512	49.0552
2025	4	2	21	32	55	0.65	94.6	75.5512	46.7081
2025	4	2	21	42	55	0.68	95.8	75.5512	48.1164
2025	4	2	21	52	55	0.68	97.5	75.5512	48.1165
2025	4	2	22	2	55	0.69	96.8	75.5512	49.0554
2025	4	2	22	12	55	0.68	96.1	75.5512	48.1165
2025	4	2	22	22	55	0.69	96.9	75.5512	48.8207
2025	4	2	22	32	55	0.65	97.3	75.5512	45.7695
2025	4	2	22	42	55	0.68	97.4	75.5512	48.5861
2025	4	2	22	52	55	0.66	100	75.5512	46.7084
2025	4	2	23	2	55	0.68	95.2	75.5512	48.5862
2025	4	2	23	12	55	0.68	98.6	75.5512	48.1168
2025	4	2	23	22	55	0.71	97.8	75.5512	49.9945
2025	4	2	23	32	55	0.7	96.8	75.5512	49.5251
2025	4	2	23	42	55	0.66	94.9	75.5512	46.7086
2025	4	2	23	52	55	0.7	98.9	75.5512	49.5252

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	3	0	2	55	0.73	96.4	75.5512	52.1072
2025	4	3	0	12	55	0.68	98.4	75.5512	47.8823
2025	4	3	0	22	55	0.69	97.3	75.5512	49.2906
2025	4	3	0	32	55	0.66	98.9	75.5512	46.474
2025	4	3	0	42	55	0.7	95.1	75.5512	49.9948
2025	4	3	0	52	55	0.67	96.5	75.5512	47.6477
2025	4	3	1	2	55	0.69	95.8	75.4856	48.777
2025	4	3	1	12	55	0.69	96	75.5512	48.8214
2025	4	3	1	22	55	0.73	98.2	75.5512	51.8727
2025	4	3	1	32	55	0.68	93.6	75.5512	48.352
2025	4	3	1	42	55	0.72	96	75.5512	51.4033
2025	4	3	1	52	55	0.64	94.1	75.4856	45.7285
2025	4	3	2	2	55	0.69	99.6	75.5512	48.5868
2025	4	3	2	12	55	0.7	98.1	75.4856	49.2461
2025	4	3	2	22	55	0.69	98.7	75.5512	48.8215
2025	4	3	2	32	55	0.69	97.4	75.4856	48.7772
2025	4	3	2	42	55	0.66	97.2	75.5512	46.7091
2025	4	3	2	52	55	0.63	98.3	75.4856	44.7906
2025	4	3	3	2	55	0.69	96.5	75.4856	49.2462
2025	4	3	3	12	55	0.7	97.6	75.4856	49.2462
2025	4	3	3	22	55	0.69	101	75.4856	48.3082
2025	4	3	3	32	55	0.64	97.7	75.4856	45.2597
2025	4	3	3	42	55	0.65	94.4	75.4856	46.1977
2025	4	3	3	52	55	0.66	98.3	75.4856	46.4322
2025	4	3	4	2	55	0.67	94.5	75.4856	47.6048
2025	4	3	4	12	55	0.63	96.9	75.4856	44.7907
2025	4	3	4	22	55	0.67	96.5	75.5512	47.4133
2025	4	3	4	32	55	0.66	100	75.4856	46.6668
2025	4	3	4	42	55	0.71	96.9	75.4856	50.1843
2025	4	3	4	52	55	0.66	97.5	75.5512	46.4745
2025	4	3	5	2	55	0.67	96.4	75.4856	47.8393
2025	4	3	5	12	55	0.69	98.5	75.4856	48.5428
2025	4	3	5	22	55	0.67	94.5	75.4856	47.6048
2025	4	3	5	32	55	0.71	98	75.4856	50.1844
2025	4	3	5	42	55	0.68	96.1	75.4856	48.5429
2025	4	3	5	52	55	0.66	96.6	75.4856	46.6668
2025	4	3	6	2	55	0.67	99.9	75.4856	46.9013
2025	4	3	6	12	55	0.69	97.1	75.4856	49.2464
2025	4	3	6	22	55	0.69	98.4	75.4856	49.0119
2025	4	3	6	32	55	0.69	98.2	75.5512	48.587
2025	4	3	6	42	55	0.67	96.2	75.5512	47.6481
2025	4	3	6	52	55	0.67	97.3	75.5512	47.8829
2025	4	3	7	2	55	0.69	99.9	75.5512	48.587
2025	4	3	7	12	55	0.67	97.9	75.5512	47.4134
2025	4	3	7	22	55	0.68	98.3	75.5512	48.1175
2025	4	3	7	32	55	0.68	98.4	75.5512	47.8828
2025	4	3	7	42	55	0.64	97.6	75.5512	45.5355
2025	4	3	7	52	55	0.65	93.8	75.5512	46.2397

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	3	8	2	55	0.67	99.3	75.5512	47.4132
2025	4	3	8	12	55	0.66	96.8	75.5512	46.9437
2025	4	3	8	22	55	0.7	97.2	75.5512	49.9951
2025	4	3	8	32	55	0.68	98.1	75.6168	48.161
2025	4	3	8	42	55	0.69	98.5	75.6168	48.6308
2025	4	3	8	52	55	0.67	98.7	75.6168	47.4561
2025	4	3	9	2	55	0.65	98.7	75.6168	46.0465
2025	4	3	9	12	55	0.69	98.5	75.6168	48.6307
2025	4	3	9	22	55	0.68	96.7	75.6168	48.1608
2025	4	3	9	32	55	0.67	99.6	75.6168	47.4559
2025	4	3	9	42	55	0.64	96.4	75.6168	45.8114
2025	4	3	9	52	55	0.69	97.1	75.6168	49.1004
2025	4	3	10	2	55	0.66	98.3	75.6168	46.751
2025	4	3	10	12	55	0.67	96.5	75.6824	47.734
2025	4	3	10	22	55	0.66	100	75.6824	46.7934
2025	4	3	10	32	55	0.7	97.8	75.6824	49.8502
2025	4	3	10	42	55	0.69	96	75.6824	49.1447
2025	4	3	10	52	55	0.69	98	75.6824	48.6744
2025	4	3	11	2	55	0.68	97.4	75.6824	48.6744
2025	4	3	11	12	55	0.69	99	75.6824	48.9095
2025	4	3	11	22	55	0.68	96.6	75.6824	48.6743
2025	4	3	11	32	55	0.68	98.1	75.6824	47.9688
2025	4	3	11	42	55	0.66	97.7	75.6824	47.0282
2025	4	3	11	52	55	0.7	98.6	75.748	49.8951
2025	4	3	12	2	55	0.65	97.8	75.6824	46.3227
2025	4	3	12	12	55	0.68	98.9	75.748	48.0122
2025	4	3	12	22	55	0.69	95.7	75.6824	49.1443
2025	4	3	12	32	55	0.67	96.8	75.748	47.5414
2025	4	3	12	42	55	0.69	96	75.748	49.1888
2025	4	3	12	52	55	0.68	97.8	75.748	48.2474
2025	4	3	13	2	55	0.7	97.2	75.748	50.1302
2025	4	3	13	12	55	0.69	97.7	75.748	48.9534
2025	4	3	13	22	55	0.7	98.1	75.748	49.4241
2025	4	3	13	32	55	0.68	96.1	75.748	48.4826
2025	4	3	13	42	55	0.65	96.6	75.748	46.5998
2025	4	3	13	52	55	0.66	96.2	75.748	47.3058
2025	4	3	14	2	55	0.69	96	75.748	48.9532
2025	4	3	14	12	55	0.72	98.9	75.748	51.0714
2025	4	3	14	22	55	0.72	95.2	75.748	51.7774
2025	4	3	14	32	55	0.69	94.9	75.6824	49.6142
2025	4	3	14	42	55	0.67	95.3	75.748	48.0118
2025	4	3	14	52	55	0.68	98	75.748	48.4825
2025	4	3	15	2	55	0.72	96.3	75.6824	51.025
2025	4	3	15	12	55	0.66	95.2	75.6824	46.7925
2025	4	3	15	22	55	0.7	98.3	75.6824	49.8494
2025	4	3	15	32	55	0.64	98.5	75.748	45.6582
2025	4	3	15	42	55	0.7	99.4	75.6824	49.6142
2025	4	3	15	52	55	0.65	97.2	75.748	46.5996

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	3	16	2	55	0.7	97.3	75.6824	49.6142
2025	4	3	16	12	55	0.72	97.8	75.6824	51.2601
2025	4	3	16	22	55	0.69	97.1	75.6824	49.1439
2025	4	3	16	32	55	0.7	96.2	75.6824	49.8493
2025	4	3	16	42	55	0.7	95.9	75.6824	49.8493
2025	4	3	16	52	55	0.71	97.9	75.6168	50.5089
2025	4	3	17	2	55	0.7	98.9	75.6168	49.3342
2025	4	3	17	12	55	0.67	99.2	75.6824	47.7331
2025	4	3	17	22	55	0.66	94.2	75.6824	47.498
2025	4	3	17	32	55	0.71	95.6	75.6824	50.7899
2025	4	3	17	42	55	0.7	97.5	75.6824	50.0845
2025	4	3	17	52	55	0.68	96.1	75.6824	48.6737
2025	4	3	18	2	55	0.67	99	75.6824	47.498
2025	4	3	18	12	55	0.68	98.1	75.6168	47.9248
2025	4	3	18	22	55	0.7	97.8	75.6168	49.8042
2025	4	3	18	32	55	0.68	96.1	75.6168	48.1597
2025	4	3	18	42	55	0.7	99.7	75.6824	49.6143
2025	4	3	18	52	55	0.72	96.8	75.6168	51.4487
2025	4	3	19	2	55	0.68	96.1	75.6168	48.1597
2025	4	3	19	12	55	0.67	100.4	75.5512	47.1772
2025	4	3	19	22	55	0.67	95.1	75.6168	47.455
2025	4	3	19	32	55	0.69	96	75.6168	48.8646
2025	4	3	19	42	55	0.7	97	75.6168	49.5694
2025	4	3	19	52	55	0.68	96.1	75.6824	48.4388
2025	4	3	20	2	55	0.69	96.9	75.6168	48.8647
2025	4	3	20	12	55	0.66	96.6	75.6168	46.7504
2025	4	3	20	22	55	0.68	98.6	75.6168	48.3949
2025	4	3	20	32	55	0.68	98.6	75.6168	48.16
2025	4	3	20	42	55	0.69	96.3	75.6168	49.3347
2025	4	3	20	52	55	0.68	98.3	75.6168	48.395
2025	4	3	21	2	55	0.72	96.8	75.6168	50.9792
2025	4	3	21	12	55	0.71	98.2	75.6168	50.2745
2025	4	3	21	22	55	0.69	97.3	75.6168	49.3348
2025	4	3	21	32	55	0.68	97.7	75.6168	48.3952
2025	4	3	21	42	55	0.68	98.6	75.6168	47.9254
2025	4	3	21	52	55	0.69	100.5	75.6168	48.3953
2025	4	3	22	2	55	0.7	95.7	75.6168	49.8049
2025	4	3	22	12	55	0.7	98.6	75.6168	49.8049
2025	4	3	22	22	55	0.67	98.7	75.6168	47.4557
2025	4	3	22	32	55	0.67	99.8	75.6168	47.4557
2025	4	3	22	42	55	0.64	97.9	75.6168	45.5763
2025	4	3	22	52	55	0.73	100.1	75.6168	51.6845
2025	4	3	23	2	55	0.68	97.5	75.6168	48.1606
2025	4	3	23	12	55	0.69	96.6	75.6168	48.8655
2025	4	3	23	22	55	0.66	95.2	75.6168	46.7511
2025	4	3	23	32	55	0.64	97.6	75.5512	45.5351
2025	4	3	23	42	55	0.67	97.9	75.6168	47.456
2025	4	3	23	52	55	0.66	98.6	75.5512	46.7088

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	4	0	2	55	0.67	95.9	75.5512	47.6477
2025	4	4	0	12	55	0.7	96.2	75.5512	49.5255
2025	4	4	0	22	55	0.68	95	75.5512	48.5866
2025	4	4	0	32	55	0.69	98.5	75.5512	48.5867
2025	4	4	0	42	55	0.67	96.5	75.5512	47.4131
2025	4	4	0	52	55	0.69	100.7	75.5512	48.352
2025	4	4	1	2	55	0.68	96.7	75.5512	48.1173
2025	4	4	1	12	55	0.72	99.4	75.5512	50.9339
2025	4	4	1	22	55	0.7	97	75.5512	49.5256
2025	4	4	1	32	55	0.67	99.9	75.4856	47.1356
2025	4	4	1	42	55	0.65	96.3	75.5512	46.4744
2025	4	4	1	52	55	0.68	96.1	75.4856	48.3082
2025	4	4	2	2	55	0.69	97.1	75.4856	48.7772
2025	4	4	2	12	55	0.64	97	75.4856	45.7287
2025	4	4	2	22	55	0.66	94.8	75.4856	47.1357
2025	4	4	2	32	55	0.65	96.9	75.4856	46.1977
2025	4	4	2	42	55	0.69	94.6	75.4856	49.4808
2025	4	4	2	52	55	0.63	96.5	75.4856	45.0252
2025	4	4	3	2	55	0.66	96.2	75.4856	47.1358
2025	4	4	3	12	55	0.68	101.1	75.4856	47.6048
2025	4	4	3	22	55	0.65	95.8	75.4856	45.9632
2025	4	4	3	32	55	0.65	94.4	75.4856	46.1978
2025	4	4	3	42	55	0.64	90.9	75.4856	45.7287
2025	4	4	3	52	55	0.66	97.7	75.4856	46.9013
2025	4	4	4	2	55	0.71	95.8	75.4856	50.4189
2025	4	4	4	12	55	0.68	95.8	75.4856	48.0738
2025	4	4	4	22	55	0.69	94.9	75.4856	49.2464
2025	4	4	4	32	55	0.63	98.3	75.4856	44.7907
2025	4	4	4	42	55	0.71	99	75.4856	50.1844
2025	4	4	4	52	55	0.68	96.9	75.4856	48.5428
2025	4	4	5	2	55	0.71	99	75.4856	50.1844
2025	4	4	5	12	55	0.67	98.1	75.4856	47.6048
2025	4	4	5	22	55	0.66	98.9	75.4856	46.6668
2025	4	4	5	32	55	0.68	100.6	75.4856	47.8393
2025	4	4	5	42	55	0.72	97.3	75.4856	51.3569
2025	4	4	5	52	55	0.68	95	75.4856	48.5428
2025	4	4	6	2	55	0.7	98.6	75.4856	49.4808
2025	4	4	6	12	55	0.69	97.1	75.4856	49.0118
2025	4	4	6	22	55	0.66	97.5	75.4856	46.4322
2025	4	4	6	32	55	0.68	98.4	75.4856	47.8392
2025	4	4	6	42	55	0.67	95	75.4856	47.8392
2025	4	4	6	52	55	0.65	98.9	75.4856	46.1977
2025	4	4	7	2	55	0.65	98.7	75.4856	45.9632
2025	4	4	7	12	55	0.68	98.6	75.4856	48.3082
2025	4	4	7	22	55	0.67	98.2	75.42	47.0928
2025	4	4	7	32	55	0.67	96.2	75.3543	47.2839
2025	4	4	7	42	55	0.66	96.3	75.42	46.6241
2025	4	4	7	52	55	0.66	99.1	75.42	46.8583

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	4	8	2	55	0.64	95.3	75.42	45.2183
2025	4	4	8	12	55	0.7	96.2	75.42	49.4355
2025	4	4	8	22	55	0.66	96.5	75.42	47.0925
2025	4	4	8	32	55	0.7	97.5	75.42	49.6697
2025	4	4	8	42	55	0.69	97.1	75.42	49.2011
2025	4	4	8	52	55	0.66	96.8	75.42	46.8581
2025	4	4	9	2	55	0.68	97.7	75.42	48.2638
2025	4	4	9	12	55	0.69	97.1	75.42	48.7323
2025	4	4	9	22	55	0.67	98.4	75.42	47.5608
2025	4	4	9	32	55	0.67	98.2	75.3543	47.2834
2025	4	4	9	42	55	0.68	98.1	75.3543	47.7515
2025	4	4	9	52	55	0.68	97.2	75.3543	48.4537
2025	4	4	10	2	55	0.68	100.8	75.3543	47.9855
2025	4	4	10	12	55	0.69	96.3	75.3543	48.9218
2025	4	4	10	22	55	0.66	98.8	75.42	46.8578
2025	4	4	10	32	55	0.66	94.3	75.42	47.0921
2025	4	4	10	42	55	0.71	100.7	75.4856	49.7145
2025	4	4	10	52	55	0.67	94.8	75.5512	47.882
2025	4	4	11	2	55	0.7	99.5	75.5512	49.0555
2025	4	4	11	12	55	0.71	97.2	75.6168	50.2747
2025	4	4	11	22	55	0.66	97.7	75.5512	46.943
2025	4	4	11	32	55	0.64	92.3	75.5512	45.7694
2025	4	4	11	42	55	0.68	96.1	75.3543	48.4535
2025	4	4	11	52	55	0.69	97.3	75.3543	49.1557
2025	4	4	12	2	55	0.7	95.4	75.3543	49.8578
2025	4	4	12	12	55	0.73	99	75.2887	51.6832
2025	4	4	12	22	55	0.71	99.3	75.3543	50.0917
2025	4	4	12	32	55	0.66	95.2	75.2887	46.5381
2025	4	4	12	42	55	0.69	97.9	75.2887	48.8767
2025	4	4	12	52	55	0.67	98.2	75.2887	47.2396
2025	4	4	13	2	55	0.72	95.8	75.2887	50.7474
2025	4	4	13	12	55	0.7	97	75.2887	49.5783
2025	4	4	13	22	55	0.71	97.7	75.2887	50.2798
2025	4	4	13	32	55	0.65	97.8	75.2887	46.0703
2025	4	4	13	42	55	0.68	95.2	75.2887	48.4088
2025	4	4	13	52	55	0.68	99.4	75.2887	48.175
2025	4	4	14	2	55	0.67	96.2	75.2887	47.2396
2025	4	4	14	12	55	0.62	96.7	75.2887	43.7316
2025	4	4	14	22	55	0.69	96	75.2887	49.1104
2025	4	4	14	32	55	0.66	97.7	75.2887	46.5379
2025	4	4	14	42	55	0.67	93.6	75.2887	47.941
2025	4	4	14	52	55	0.7	97.3	75.2887	49.578
2025	4	4	15	2	55	0.7	96	75.2887	49.3441
2025	4	4	15	12	55	0.67	97.6	75.2887	47.4732
2025	4	4	15	22	55	0.66	100.4	75.2887	46.0701
2025	4	4	15	32	55	0.64	95.6	75.3543	45.1758
2025	4	4	15	42	55	0.68	98	75.2887	48.1748
2025	4	4	15	52	55	0.66	97.4	75.2887	46.5378

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	4	16	2	55	0.64	94.1	75.2887	45.8362
2025	4	4	16	12	55	0.65	94.7	75.3543	45.878
2025	4	4	16	22	55	0.68	96.3	75.2887	48.4086
2025	4	4	16	32	55	0.66	96	75.2887	47.0054
2025	4	4	16	42	55	0.69	97.4	75.2887	48.6425
2025	4	4	16	52	55	0.62	96.7	75.3543	43.7713
2025	4	4	17	2	55	0.69	96.9	75.3543	48.6868
2025	4	4	17	12	55	0.7	96.7	75.3543	49.6231
2025	4	4	17	22	55	0.66	98	75.2887	46.7716
2025	4	4	17	32	55	0.67	98.4	75.2887	47.4732
2025	4	4	17	42	55	0.67	96.7	75.2887	47.4732
2025	4	4	17	52	55	0.68	96.1	75.2887	47.9409
2025	4	4	18	2	55	0.68	96.4	75.3543	47.9847
2025	4	4	18	12	55	0.7	95.1	75.2887	50.0457
2025	4	4	18	22	55	0.71	96.9	75.3543	50.0913
2025	4	4	18	32	55	0.72	98.1	75.3543	51.0276
2025	4	4	18	42	55	0.7	98.3	75.2887	49.578
2025	4	4	18	52	55	0.73	96.9	75.3543	51.9639
2025	4	4	19	2	55	0.71	97.4	75.3543	50.3255
2025	4	4	19	12	55	0.7	99.7	75.3543	49.1551
2025	4	4	19	22	55	0.68	98	75.3543	48.2188
2025	4	4	19	32	55	0.65	95.8	75.3543	46.1122
2025	4	4	19	42	55	0.66	97.7	75.3543	46.5804
2025	4	4	19	52	55	0.73	97.3	75.3543	51.4959
2025	4	4	20	2	55	0.69	96.3	75.3543	48.6871
2025	4	4	20	12	55	0.74	96.9	75.3543	52.4323
2025	4	4	20	22	55	0.67	96.5	75.2887	47.2396
2025	4	4	20	32	55	0.68	97.5	75.3543	47.985
2025	4	4	20	42	55	0.66	94	75.3543	47.0487
2025	4	4	20	52	55	0.7	96.8	75.3543	49.3895
2025	4	4	21	2	55	0.67	97.6	75.3543	47.5169
2025	4	4	21	12	55	0.7	97.9	75.42	49.2003
2025	4	4	21	22	55	0.7	98.4	75.42	49.2003
2025	4	4	21	32	55	0.68	97.5	75.4856	48.3071
2025	4	4	21	42	55	0.61	98.3	75.4856	43.3827
2025	4	4	21	52	55	0.69	100.7	75.4856	48.5417
2025	4	4	22	2	55	0.68	98.1	75.4856	47.8383
2025	4	4	22	12	55	0.68	97.5	75.5512	48.1165
2025	4	4	22	22	55	0.68	98.1	75.5512	48.1166
2025	4	4	22	32	55	0.72	98.7	75.6168	50.7445
2025	4	4	22	42	55	0.7	95.6	75.6168	50.0398
2025	4	4	22	52	55	0.69	96.5	75.6168	49.335
2025	4	4	23	2	55	0.7	98.9	75.6168	49.57
2025	4	4	23	12	55	0.68	97.2	75.6168	48.6303
2025	4	4	23	22	55	0.69	100.1	75.6168	48.8653
2025	4	4	23	32	55	0.71	98.2	75.6168	50.5099
2025	4	4	23	42	55	0.66	97.4	75.6824	47.0286
2025	4	4	23	52	55	0.68	97.7	75.6824	48.4395

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	5	0	2	55	0.68	95	75.6824	48.4395
2025	4	5	0	12	55	0.68	96.9	75.6824	48.4396
2025	4	5	0	22	55	0.73	97.2	75.6824	52.2019
2025	4	5	0	32	55	0.72	97.3	75.6824	51.4965
2025	4	5	0	42	55	0.68	95	75.6824	48.6748
2025	4	5	0	52	55	0.71	97.4	75.6824	50.556
2025	4	5	1	2	55	0.7	97.6	75.6824	49.6155
2025	4	5	1	12	55	0.68	97.2	75.748	48.7191
2025	4	5	1	22	55	0.72	100.5	75.748	50.602
2025	4	5	1	32	55	0.65	96.9	75.748	46.3656
2025	4	5	1	42	55	0.66	94.5	75.748	47.5424
2025	4	5	1	52	55	0.67	100.7	75.748	47.307
2025	4	5	2	2	55	0.69	96.5	75.748	49.4253
2025	4	5	2	12	55	0.71	95.8	75.8137	50.648
2025	4	5	2	22	55	0.69	97.7	75.8137	48.7634
2025	4	5	2	32	55	0.7	98.1	75.8137	49.9413
2025	4	5	2	42	55	0.68	97.5	75.8793	48.336
2025	4	5	2	52	55	0.71	98.2	75.9449	50.7398
2025	4	5	3	2	55	0.69	97.6	76.0105	49.3684
2025	4	5	3	12	55	0.67	94.2	76.0761	48.2309
2025	4	5	3	22	55	0.71	98.5	76.1417	50.4042
2025	4	5	3	32	55	0.7	96.7	76.1417	50.1675
2025	4	5	3	42	55	0.71	98.7	76.1417	50.8775
2025	4	5	3	52	55	0.68	95.3	76.1417	48.7477
2025	4	5	4	2	55	0.7	95.6	76.2074	50.4497
2025	4	5	4	12	55	0.7	97.5	76.2074	50.2128
2025	4	5	4	22	55	0.72	96.1	76.2074	51.3971
2025	4	5	4	32	55	0.71	96.3	76.273	51.2063
2025	4	5	4	42	55	0.67	98.7	76.273	48.1245
2025	4	5	4	52	55	0.71	98	76.273	50.4951
2025	4	5	5	2	55	0.69	99.6	76.273	49.3098
2025	4	5	5	12	55	0.71	98.7	76.273	50.9692
2025	4	5	5	22	55	0.68	98.3	76.3386	48.6423
2025	4	5	5	32	55	0.72	98.1	76.3386	51.727
2025	4	5	5	42	55	0.68	94.7	76.3386	49.3542
2025	4	5	5	52	55	0.72	95.2	76.3386	52.2015
2025	4	5	6	2	55	0.7	96.7	76.3386	50.3033
2025	4	5	6	12	55	0.67	94.8	76.4042	48.2111
2025	4	5	6	22	55	0.68	95.8	76.4042	48.9236
2025	4	5	6	32	55	0.71	98	76.4042	50.586
2025	4	5	6	42	55	0.75	99.8	76.4698	53.4839
2025	4	5	6	52	55	0.68	98.4	76.4698	48.4921
2025	4	5	7	2	55	0.71	96.1	76.4698	51.1068
2025	4	5	7	12	55	0.7	96.5	76.5354	50.201
2025	4	5	7	22	55	0.69	98.2	76.6011	49.7697
2025	4	5	7	32	55	0.74	97.9	76.7323	53.1987
2025	4	5	7	42	55	0.73	98.3	76.7979	52.2911
2025	4	5	7	52	55	0.74	99.9	76.8635	53.2938

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	5	8	2	55	0.76	98.9	76.8635	54.9666
2025	4	5	8	12	55	0.73	95.9	76.9291	53.1021
2025	4	5	8	22	55	0.72	98.9	76.9291	52.1452
2025	4	5	8	32	55	0.73	96.4	76.9291	53.102
2025	4	5	8	42	55	0.75	97	76.9948	54.3464
2025	4	5	8	52	55	0.73	96.4	77.0604	53.1966
2025	4	5	9	2	55	0.74	99.4	77.0604	53.6759
2025	4	5	9	12	55	0.67	97.3	77.0604	48.8833
2025	4	5	9	22	55	0.74	98.2	77.126	53.4837
2025	4	5	9	32	55	0.71	96.9	77.1916	51.8509
2025	4	5	9	42	55	0.74	99.5	77.1916	53.0511
2025	4	5	9	52	55	0.71	97.7	77.1916	51.6107
2025	4	5	10	2	55	0.73	97.7	77.2572	53.0982
2025	4	5	10	12	55	0.73	99	77.3228	52.9048
2025	4	5	10	22	55	0.77	96.4	77.3228	55.7905
2025	4	5	10	32	55	0.73	98	77.3885	53.1923
2025	4	5	10	42	55	0.72	94.4	77.3885	52.7109
2025	4	5	10	52	55	0.76	97.2	77.3885	55.3584
2025	4	5	11	2	55	0.72	94.7	77.4541	52.7575
2025	4	5	11	12	55	0.79	96.9	77.4541	57.8164
2025	4	5	11	22	55	0.72	96.8	77.5197	52.8042
2025	4	5	11	32	55	0.69	98.7	77.5197	50.393
2025	4	5	11	42	55	0.76	98.7	77.5853	55.2641
2025	4	5	11	52	55	0.77	97.6	77.5853	55.988
2025	4	5	12	2	55	0.73	97.2	77.6509	53.3805
2025	4	5	12	12	55	0.74	96.8	77.7165	54.3947
2025	4	5	12	22	55	0.7	98.4	77.7822	51.0551
2025	4	5	12	32	55	0.75	96	77.7822	55.1685
2025	4	5	12	42	55	0.76	96.5	77.7822	55.4104
2025	4	5	12	52	55	0.76	99.4	77.9134	55.5082
2025	4	5	13	2	55	0.75	97.3	77.9134	55.0233
2025	4	5	13	12	55	0.8	96.2	77.979	58.4683
2025	4	5	13	22	55	0.73	99.3	77.979	53.3735
2025	4	5	13	32	55	0.76	98.2	78.0446	55.363
2025	4	5	13	42	55	0.71	97.2	78.1102	52.2522
2025	4	5	13	52	55	0.74	96.4	78.1102	54.1964
2025	4	5	14	2	55	0.75	97.8	78.1758	54.7305
2025	4	5	14	12	55	0.75	97.5	78.1758	55.4602
2025	4	5	14	22	55	0.71	95	78.1758	52.7844
2025	4	5	14	32	55	0.74	97.1	78.1758	54.7304
2025	4	5	14	42	55	0.74	96.9	78.2415	54.5349
2025	4	5	14	52	55	0.7	98.4	78.2415	51.3699
2025	4	5	15	2	55	0.72	96.8	78.2415	53.3176
2025	4	5	15	12	55	0.8	99.4	78.2415	58.9172
2025	4	5	15	22	55	0.74	97.9	78.3071	54.0953
2025	4	5	15	32	55	0.72	96.8	78.3071	53.3643
2025	4	5	15	42	55	0.74	97.4	78.3071	54.5827
2025	4	5	15	52	55	0.74	95.9	78.3727	54.3866

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	5	16	2	55	0.78	96.3	78.3727	57.3132
2025	4	5	16	12	55	0.73	96.7	78.3727	54.1427
2025	4	5	16	22	55	0.8	99.7	78.4383	58.828
2025	4	5	16	32	55	0.75	96.8	78.4383	55.1665
2025	4	5	16	42	55	0.78	95.8	78.4383	57.8516
2025	4	5	16	52	55	0.75	98.1	78.5039	55.2147
2025	4	5	17	2	55	0.78	96.1	78.5039	57.4136
2025	4	5	17	12	55	0.77	95.6	78.5696	57.4638
2025	4	5	17	22	55	0.74	96.6	78.6352	54.8218
2025	4	5	17	32	55	0.74	94.8	78.7664	55.4078
2025	4	5	17	42	55	0.74	95.6	78.832	55.4561
2025	4	5	17	52	55	0.69	96.3	78.832	51.53
2025	4	5	18	2	55	0.74	96.4	78.8976	54.7676
2025	4	5	18	12	55	0.77	96.6	78.8976	56.978
2025	4	5	18	22	55	0.75	96	78.9633	55.7985
2025	4	5	18	32	55	0.71	96.9	78.9633	53.0946
2025	4	5	18	42	55	0.8	95.7	78.9633	59.4857
2025	4	5	18	52	55	0.73	97.3	78.9633	54.0779
2025	4	5	19	2	55	0.8	94.5	78.9633	59.4857
2025	4	5	19	12	55	0.73	94.1	79.0289	54.617
2025	4	5	19	22	55	0.73	94.4	79.0289	54.8631
2025	4	5	19	32	55	0.75	96.3	79.0289	55.6012
2025	4	5	19	42	55	0.75	96.8	79.0289	55.8472
2025	4	5	19	52	55	0.77	94.1	79.0289	57.8155
2025	4	5	20	2	55	0.77	93.9	79.0945	57.8657
2025	4	5	20	12	55	0.74	97.4	79.0945	55.1572
2025	4	5	20	22	55	0.73	98.1	79.0945	53.926
2025	4	5	20	32	55	0.73	97.7	79.0945	54.4185
2025	4	5	20	42	55	0.77	94.9	79.1601	57.4232
2025	4	5	20	52	55	0.76	98.2	79.2257	56.2397
2025	4	5	21	2	55	0.75	95.5	79.357	56.3371
2025	4	5	21	12	55	0.76	97.9	79.4226	56.8805
2025	4	5	21	22	55	0.76	95.7	79.4226	57.3752
2025	4	5	21	32	55	0.75	98.8	79.4882	56.1872
2025	4	5	21	42	55	0.76	97.2	79.4882	56.9298
2025	4	5	21	52	55	0.78	95.1	79.4882	58.4149
2025	4	5	22	2	55	0.78	96.3	79.4882	58.6625
2025	4	5	22	12	55	0.79	97.9	79.4882	58.6626
2025	4	5	22	22	55	0.76	97.4	79.4882	57.1775
2025	4	5	22	32	55	0.77	97.1	79.5538	57.7224
2025	4	5	22	42	55	0.77	96.2	79.5538	57.4747
2025	4	5	22	52	55	0.79	97.4	79.5538	59.2089
2025	4	5	23	2	55	0.78	97.5	79.5538	58.7135
2025	4	5	23	12	55	0.78	97.5	79.5538	58.218
2025	4	5	23	22	55	0.8	96.1	79.6194	60.0039
2025	4	5	23	32	55	0.76	97.5	79.6194	56.7806
2025	4	5	23	42	55	0.76	98.7	79.6194	56.7807
2025	4	5	23	52	55	0.78	98.5	79.6851	58.3186

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	6	0	2	55	0.78	98.3	79.6851	58.0705
2025	4	6	0	12	55	0.76	96.4	79.7507	57.127
2025	4	6	0	22	55	0.76	96.7	79.8819	56.9765
2025	4	6	0	32	55	0.76	98	79.9475	56.7764
2025	4	6	0	42	55	0.75	97.2	79.9475	56.7764
2025	4	6	0	52	55	0.78	95.3	80.0131	58.819
2025	4	6	1	2	55	0.83	98	80.0131	62.3083
2025	4	6	1	12	55	0.77	95.9	80.0131	58.0714
2025	4	6	1	22	55	0.75	97.8	80.0131	56.0775
2025	4	6	1	32	55	0.75	96.8	80.0787	56.3751
2025	4	6	1	42	55	0.76	96.7	80.0787	57.1234
2025	4	6	1	52	55	0.77	96.1	80.0787	58.1212
2025	4	6	2	2	55	0.77	97.1	80.0787	57.8718
2025	4	6	2	12	55	0.78	96	80.0787	58.8696
2025	4	6	2	22	55	0.79	97.4	80.0787	59.3685
2025	4	6	2	32	55	0.78	96.5	80.0787	58.8696
2025	4	6	2	42	55	0.77	97.3	80.1444	58.4207
2025	4	6	2	52	55	0.79	95.9	80.1444	60.1684
2025	4	6	3	2	55	0.76	97.4	80.1444	57.6718
2025	4	6	3	12	55	0.78	95.5	80.1444	59.4194
2025	4	6	3	22	55	0.76	96.4	80.1444	57.6718
2025	4	6	3	32	55	0.79	95.3	80.21	59.7201
2025	4	6	3	42	55	0.79	95.9	80.21	60.2199
2025	4	6	3	52	55	0.81	96	80.21	61.4693
2025	4	6	4	2	55	0.75	98	80.21	56.7216
2025	4	6	4	12	55	0.78	98.5	80.21	58.7206
2025	4	6	4	22	55	0.8	95.7	80.21	60.4697
2025	4	6	4	32	55	0.76	95.2	80.21	57.971
2025	4	6	4	42	55	0.79	96.7	80.21	59.4703
2025	4	6	4	52	55	0.81	98.2	80.2756	61.0216
2025	4	6	5	2	55	0.77	97.1	80.2756	58.5207
2025	4	6	5	12	55	0.8	97.8	80.2756	60.2714
2025	4	6	5	22	55	0.75	98.5	80.2756	56.7701
2025	4	6	5	32	55	0.79	96.7	80.2756	59.5211
2025	4	6	5	42	55	0.74	96.6	80.2756	56.0199
2025	4	6	5	52	55	0.76	95.2	80.2756	57.5204
2025	4	6	6	2	55	0.79	96.2	80.2756	59.5211
2025	4	6	6	12	55	0.8	97.5	80.3412	60.5731
2025	4	6	6	22	55	0.79	95.7	80.3412	59.8222
2025	4	6	6	32	55	0.75	96.1	80.3412	56.5683
2025	4	6	6	42	55	0.79	95	80.3412	60.3228
2025	4	6	6	52	55	0.84	97.2	80.4068	63.3805
2025	4	6	7	2	55	0.78	96.8	80.4068	58.8712
2025	4	6	7	12	55	0.8	97.8	80.4068	60.3742
2025	4	6	7	22	55	0.75	94.2	80.4068	57.368
2025	4	6	7	32	55	0.77	96.6	80.4068	58.6205
2025	4	6	7	42	55	0.78	97.7	80.4724	59.4227
2025	4	6	7	52	55	0.79	98.2	80.4724	59.4226

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	6	8	2	55	0.78	94.3	80.4724	59.4226
2025	4	6	8	12	55	0.73	96.4	80.4724	55.6616
2025	4	6	8	22	55	0.8	96.8	80.5381	60.7278
2025	4	6	8	32	55	0.82	100.3	80.4724	61.9297
2025	4	6	8	42	55	0.74	96.1	80.5381	56.4617
2025	4	6	8	52	55	0.82	96.9	80.5381	62.4842
2025	4	6	9	2	55	0.79	99.3	80.5381	59.7238
2025	4	6	9	12	55	0.78	96.1	80.4724	58.9207
2025	4	6	9	22	55	0.79	99.5	80.5381	59.7237
2025	4	6	9	32	55	0.81	96.7	80.5381	61.7311
2025	4	6	9	42	55	0.81	96.8	80.5381	61.2292
2025	4	6	9	52	55	0.74	98.7	80.5381	55.7085
2025	4	6	10	2	55	0.8	96.3	80.5381	60.9781
2025	4	6	10	12	55	0.75	99.1	80.5381	56.7121
2025	4	6	10	22	55	0.81	96.1	80.5381	61.2289
2025	4	6	10	32	55	0.76	97.4	80.5381	57.7157
2025	4	6	10	42	55	0.78	97	80.6037	59.2717
2025	4	6	10	52	55	0.76	96.4	80.5381	57.7156
2025	4	6	11	2	55	0.75	95.2	80.6037	57.5135
2025	4	6	11	12	55	0.78	96.7	80.5381	59.472
2025	4	6	11	22	55	0.79	97.4	80.5381	59.9738
2025	4	6	11	32	55	0.79	97.9	80.6037	59.5225
2025	4	6	11	42	55	0.81	97	80.5381	61.4793
2025	4	6	11	52	55	0.77	94.9	80.6037	58.5178
2025	4	6	12	2	55	0.77	98.6	80.5381	57.9661
2025	4	6	12	12	55	0.8	98.7	80.6037	60.7781
2025	4	6	12	22	55	0.75	94.3	80.6037	57.0108
2025	4	6	12	32	55	0.77	97.6	80.6037	58.5176
2025	4	6	12	42	55	0.8	96.1	80.6037	60.7779
2025	4	6	12	52	55	0.76	97.2	80.6037	57.7641
2025	4	6	13	2	55	0.79	96.7	80.6037	59.7732
2025	4	6	13	12	55	0.79	96.2	80.6037	60.0243
2025	4	6	13	22	55	0.74	97.7	80.6037	56.0059
2025	4	6	13	32	55	0.74	94.8	80.6037	56.7593
2025	4	6	13	42	55	0.79	97.9	80.6037	59.773
2025	4	6	13	52	55	0.79	96.9	80.5381	60.224
2025	4	6	14	2	55	0.79	96.9	80.6037	60.0241
2025	4	6	14	12	55	0.75	97.7	80.5381	57.2127
2025	4	6	14	22	55	0.74	95.6	80.5381	56.7109
2025	4	6	14	32	55	0.78	95.1	80.5381	59.2201
2025	4	6	14	42	55	0.76	95.7	80.5381	57.7145
2025	4	6	14	52	55	0.78	98	80.5381	59.2201
2025	4	6	15	2	55	0.79	95.7	80.5381	60.4747
2025	4	6	15	12	55	0.76	95.9	80.4724	57.916
2025	4	6	15	22	55	0.77	95.3	80.4724	58.9189
2025	4	6	15	32	55	0.77	98.8	80.4724	58.1667
2025	4	6	15	42	55	0.76	98	80.4724	57.4146
2025	4	6	15	52	55	0.77	96.2	80.4724	58.1667

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	6	16	2	55	0.78	95.8	80.4068	59.1192
2025	4	6	16	12	55	0.81	96.3	80.4068	61.1233
2025	4	6	16	22	55	0.75	95.3	80.4068	56.8647
2025	4	6	16	32	55	0.78	96.3	80.4068	59.1193
2025	4	6	16	42	55	0.78	96.3	80.4068	59.1193
2025	4	6	16	52	55	0.79	99.8	80.4068	59.6203
2025	4	6	17	2	55	0.75	98.5	80.4068	56.8647
2025	4	6	17	12	55	0.79	96.7	80.4068	60.1213
2025	4	6	17	22	55	0.79	97.1	80.3412	60.0701
2025	4	6	17	32	55	0.78	96.1	80.2756	58.7684
2025	4	6	17	42	55	0.75	96.6	80.2756	56.5177
2025	4	6	17	52	55	0.77	97.1	80.1444	58.4184
2025	4	6	18	2	55	0.79	96.4	80.0787	59.6156
2025	4	6	18	12	55	0.8	97.7	80.0787	60.6134
2025	4	6	18	22	55	0.74	96.4	80.0787	55.6247
2025	4	6	18	32	55	0.8	96.2	80.0131	60.0631
2025	4	6	18	42	55	0.75	98.3	80.0131	56.3248
2025	4	6	18	52	55	0.81	96.1	80.0131	60.8109
2025	4	6	19	2	55	0.81	98.7	79.9475	60.5098
2025	4	6	19	12	55	0.81	96.8	79.9475	60.7589
2025	4	6	19	22	55	0.76	99.5	79.9475	56.7747
2025	4	6	19	32	55	0.79	96.2	79.9475	59.2649
2025	4	6	19	42	55	0.77	97.6	79.9475	58.0199
2025	4	6	19	52	55	0.76	96.5	79.8819	56.9749
2025	4	6	20	2	55	0.78	98.2	79.8819	58.4678
2025	4	6	20	12	55	0.75	97.6	79.8819	56.2287
2025	4	6	20	22	55	0.79	97.9	79.8163	58.9149
2025	4	6	20	32	55	0.76	99.5	79.8163	56.6777
2025	4	6	20	42	55	0.8	95	79.8163	60.1579
2025	4	6	20	52	55	0.77	95.3	79.7507	58.3677
2025	4	6	21	2	55	0.77	98.6	79.7507	57.6226
2025	4	6	21	12	55	0.78	95.3	79.7507	59.1129
2025	4	6	21	22	55	0.73	99	79.7507	54.8906
2025	4	6	21	32	55	0.75	96.8	79.6851	56.3324
2025	4	6	21	42	55	0.75	96.5	79.6851	56.3325
2025	4	6	21	52	55	0.75	94.5	79.6851	56.8288
2025	4	6	22	2	55	0.75	95.3	79.6851	56.3326
2025	4	6	22	12	55	0.78	96.8	79.6194	58.5157
2025	4	6	22	22	55	0.74	98.9	79.6194	55.5403
2025	4	6	22	32	55	0.74	97.7	79.6194	55.2924
2025	4	6	22	42	55	0.81	97.2	79.6194	60.7473
2025	4	6	22	52	55	0.75	97.6	79.5538	55.9881
2025	4	6	23	2	55	0.75	96.6	79.5538	55.9881
2025	4	6	23	12	55	0.73	95.9	79.5538	54.7495
2025	4	6	23	22	55	0.76	95.4	79.5538	57.2269
2025	4	6	23	32	55	0.78	96.6	79.4882	58.1677
2025	4	6	23	42	55	0.72	99.2	79.4882	53.4648
2025	4	6	23	52	55	0.81	96.3	79.4882	60.3955

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	7	0	2	55	0.77	95.6	79.4882	58.1678
2025	4	7	0	12	55	0.76	97.2	79.4882	57.1777
2025	4	7	0	22	55	0.74	94.6	79.4882	55.9402
2025	4	7	0	32	55	0.77	97.1	79.4226	57.6231
2025	4	7	0	42	55	0.74	96.6	79.4226	55.3973
2025	4	7	0	52	55	0.8	99.2	79.4226	59.6016
2025	4	7	1	2	55	0.71	96.3	79.4226	53.4189
2025	4	7	1	12	55	0.79	95.9	79.4226	59.6016
2025	4	7	1	22	55	0.77	95.6	79.357	57.5734
2025	4	7	1	32	55	0.74	95.8	79.357	55.5967
2025	4	7	1	42	55	0.77	97.6	79.357	57.3264
2025	4	7	1	52	55	0.76	97.2	79.357	57.0793
2025	4	7	2	2	55	0.76	96.7	79.2913	56.5362
2025	4	7	2	12	55	0.73	98.6	79.2913	54.0673
2025	4	7	2	22	55	0.73	97.7	79.2913	54.808
2025	4	7	2	32	55	0.78	97.5	79.2913	58.0175
2025	4	7	2	42	55	0.76	96.5	79.2257	56.4873
2025	4	7	2	52	55	0.75	96	79.2257	56.2406
2025	4	7	3	2	55	0.77	96.1	79.2257	57.474
2025	4	7	3	12	55	0.75	97	79.1601	55.9455
2025	4	7	3	22	55	0.76	96	79.0945	56.3895
2025	4	7	3	32	55	0.73	99.8	79.0289	54.1263
2025	4	7	3	42	55	0.77	98.6	78.9633	56.7833
2025	4	7	3	52	55	0.73	95.9	78.9633	54.3251
2025	4	7	4	2	55	0.77	96.6	78.8976	57.4708
2025	4	7	4	12	55	0.76	96.2	78.8976	56.2428
2025	4	7	4	22	55	0.77	97.6	78.8976	56.9795
2025	4	7	4	32	55	0.75	95	78.8976	55.7515
2025	4	7	4	42	55	0.73	94.4	78.832	54.4761
2025	4	7	4	52	55	0.75	96.5	78.832	55.9484
2025	4	7	5	2	55	0.76	95	78.832	56.4392
2025	4	7	5	12	55	0.73	96.2	78.832	53.9853
2025	4	7	5	22	55	0.7	98.3	78.832	52.0222
2025	4	7	5	32	55	0.72	97.9	78.832	53.0037
2025	4	7	5	42	55	0.74	97.6	78.7664	54.919
2025	4	7	5	52	55	0.74	95.3	78.7664	55.1642
2025	4	7	6	2	55	0.76	95	78.7664	56.39
2025	4	7	6	12	55	0.72	95.7	78.7664	53.6931
2025	4	7	6	22	55	0.73	96.7	78.7664	53.9382
2025	4	7	6	32	55	0.75	96.6	78.7664	55.4093
2025	4	7	6	42	55	0.74	97.9	78.7664	54.9189
2025	4	7	6	52	55	0.71	97.7	78.7664	52.7123
2025	4	7	7	2	55	0.75	96.8	78.7008	55.361
2025	4	7	7	12	55	0.71	96.9	78.7008	52.9113
2025	4	7	7	22	55	0.75	97.8	78.7008	55.6059
2025	4	7	7	32	55	0.73	97.4	78.7008	54.381
2025	4	7	7	42	55	0.73	95.7	78.7008	54.381
2025	4	7	7	52	55	0.73	97.2	78.7008	54.3809

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	7	8	2	55	0.77	97.4	78.7008	56.8305
2025	4	7	8	12	55	0.75	95	78.7008	56.0955
2025	4	7	8	22	55	0.74	96.9	78.6352	54.5781
2025	4	7	8	32	55	0.76	97	78.6352	56.0466
2025	4	7	8	42	55	0.75	98.5	78.6352	55.557
2025	4	7	8	52	55	0.71	99.3	78.5696	52.0851
2025	4	7	9	2	55	0.73	97	78.5039	53.7497
2025	4	7	9	12	55	0.73	97.5	78.3727	53.6557
2025	4	7	9	22	55	0.76	99.5	78.3727	55.3629
2025	4	7	9	32	55	0.72	98.4	78.3071	52.8777
2025	4	7	9	42	55	0.73	97.5	78.3071	53.6087
2025	4	7	9	52	55	0.74	95.6	78.3071	54.5834
2025	4	7	10	2	55	0.77	97.3	78.3071	56.7764
2025	4	7	10	12	55	0.74	97.3	78.2415	54.7789
2025	4	7	10	22	55	0.74	97.7	78.2415	54.292
2025	4	7	10	32	55	0.74	97.6	78.2415	54.5354
2025	4	7	10	42	55	0.71	96.6	78.2415	52.5877
2025	4	7	10	52	55	0.73	97	78.2415	53.5615
2025	4	7	11	2	55	0.7	95.9	78.2415	51.6137
2025	4	7	11	12	55	0.7	95.7	78.2415	51.3702
2025	4	7	11	22	55	0.7	96.7	78.2415	51.6135
2025	4	7	11	32	55	0.75	97.5	78.3071	55.5575
2025	4	7	11	42	55	0.7	96	78.2415	51.3699
2025	4	7	11	52	55	0.7	97	78.2415	51.3699
2025	4	7	12	2	55	0.72	98.6	78.2415	53.074
2025	4	7	12	12	55	0.75	96.8	78.2415	55.0216
2025	4	7	12	22	55	0.7	96.7	78.1758	51.5679
2025	4	7	12	32	55	0.69	97.3	78.1758	51.0813
2025	4	7	12	42	55	0.71	98	78.1758	52.0542
2025	4	7	12	52	55	0.72	93.4	78.1758	53.5137
2025	4	7	13	2	55	0.74	96.9	78.1758	54.2433
2025	4	7	13	12	55	0.69	96.3	78.1758	50.8379
2025	4	7	13	22	55	0.7	97	78.1102	51.7653
2025	4	7	13	32	55	0.73	98	78.1102	53.4665
2025	4	7	13	42	55	0.75	99.6	78.1102	54.6816
2025	4	7	13	52	55	0.71	95.6	78.1102	52.4943
2025	4	7	14	2	55	0.73	97	78.1102	53.4664
2025	4	7	14	12	55	0.73	94.1	78.1102	54.1954
2025	4	7	14	22	55	0.72	96.1	78.1102	52.7372
2025	4	7	14	32	55	0.7	99.7	78.1102	51.036
2025	4	7	14	42	55	0.7	97	78.0446	51.2339
2025	4	7	14	52	55	0.71	97.7	78.0446	52.2052
2025	4	7	15	2	55	0.71	97.1	77.979	52.4019
2025	4	7	15	12	55	0.75	98.6	77.979	54.5852
2025	4	7	15	22	55	0.75	100.4	77.9134	54.2948
2025	4	7	15	32	55	0.72	98.4	77.979	52.887
2025	4	7	15	42	55	0.71	95.6	77.979	52.4018
2025	4	7	15	52	55	0.76	99.2	77.9134	55.5067

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	7	16	2	55	0.73	96.9	77.9134	53.81
2025	4	7	16	12	55	0.66	96.8	77.9134	48.4775
2025	4	7	16	22	55	0.75	97.8	77.9134	54.5372
2025	4	7	16	32	55	0.72	97	77.9134	53.0828
2025	4	7	16	42	55	0.73	97	77.9134	53.5676
2025	4	7	16	52	55	0.74	97.3	77.8478	54.4891
2025	4	7	17	2	55	0.74	96.1	77.8478	54.4892
2025	4	7	17	12	55	0.71	98.8	77.8478	51.8252
2025	4	7	17	22	55	0.73	97.7	77.8478	53.7626
2025	4	7	17	32	55	0.73	98.3	77.8478	53.2783
2025	4	7	17	42	55	0.74	95.8	77.8478	54.4892
2025	4	7	17	52	55	0.74	95.1	77.8478	54.4892
2025	4	7	18	2	55	0.76	95.7	77.8478	55.7001
2025	4	7	18	12	55	0.7	98.4	77.8478	50.8566
2025	4	7	18	22	55	0.71	96.1	77.8478	52.0675
2025	4	7	18	32	55	0.71	98	77.8478	51.8254
2025	4	7	18	42	55	0.73	97.3	77.8478	53.2784
2025	4	7	18	52	55	0.77	97.9	77.7822	55.8931
2025	4	7	19	2	55	0.78	98	77.7822	56.8609
2025	4	7	19	12	55	0.73	97	77.7822	53.2316
2025	4	7	19	22	55	0.7	96.2	77.7822	51.0539
2025	4	7	19	32	55	0.77	98.1	77.7822	56.1352
2025	4	7	19	42	55	0.74	92.8	77.7822	54.6834
2025	4	7	19	52	55	0.75	96.8	77.7822	54.6835
2025	4	7	20	2	55	0.7	96.4	77.7822	51.538
2025	4	7	20	12	55	0.71	98.7	77.7822	52.0219
2025	4	7	20	22	55	0.7	96.2	77.7822	51.2961
2025	4	7	20	32	55	0.7	97.3	77.7165	51.0091
2025	4	7	20	42	55	0.75	99.3	77.7165	54.8772
2025	4	7	20	52	55	0.71	95.9	77.7165	51.7344
2025	4	7	21	2	55	0.74	97.4	77.7165	53.9102
2025	4	7	21	12	55	0.69	97.4	77.7165	50.5258
2025	4	7	21	22	55	0.73	97	77.7165	53.4268
2025	4	7	21	32	55	0.77	97.3	77.7165	56.3279
2025	4	7	21	42	55	0.69	96	77.7165	50.5259
2025	4	7	21	52	55	0.73	98.2	77.7165	53.4269
2025	4	7	22	2	55	0.73	97.3	77.7165	53.1852
2025	4	7	22	12	55	0.75	97.8	77.6509	54.5876
2025	4	7	22	22	55	0.73	95.7	77.7165	53.6688
2025	4	7	22	32	55	0.74	98.2	77.7165	53.6689
2025	4	7	22	42	55	0.72	97	77.7165	52.9437
2025	4	7	22	52	55	0.75	94.7	77.7165	55.3612
2025	4	7	23	2	55	0.75	95.8	77.7165	54.636
2025	4	7	23	12	55	0.74	96.6	77.6509	54.3463
2025	4	7	23	22	55	0.74	95.6	77.6509	54.3463
2025	4	7	23	32	55	0.73	95.4	77.6509	53.6218
2025	4	7	23	42	55	0.71	94.2	77.6509	52.4141
2025	4	7	23	52	55	0.73	97.2	77.6509	53.3803

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	8	0	2	55	0.75	95.5	77.6509	54.8296
2025	4	8	0	12	55	0.73	97	77.6509	53.1388
2025	4	8	0	22	55	0.7	97.5	77.6509	51.4481
2025	4	8	0	32	55	0.7	95.7	77.6509	51.2066
2025	4	8	0	42	55	0.75	99.1	77.6509	54.5882
2025	4	8	0	52	55	0.71	96.6	77.6509	51.9313
2025	4	8	1	2	55	0.68	96.1	77.6509	49.999
2025	4	8	1	12	55	0.71	97.2	77.6509	51.6898
2025	4	8	1	22	55	0.72	95.8	77.6509	52.656
2025	4	8	1	32	55	0.76	98.2	77.6509	55.3129
2025	4	8	1	42	55	0.72	97.3	77.6509	52.8975
2025	4	8	1	52	55	0.73	98.1	77.6509	52.8976
2025	4	8	2	2	55	0.72	100	77.6509	52.173
2025	4	8	2	12	55	0.71	100.6	77.6509	51.6899
2025	4	8	2	22	55	0.73	95.2	77.6509	53.3807
2025	4	8	2	32	55	0.74	98.7	77.6509	53.8638
2025	4	8	2	42	55	0.7	94.8	77.6509	51.6899
2025	4	8	2	52	55	0.72	97.6	77.6509	52.4146
2025	4	8	3	2	55	0.73	97.7	77.5853	53.3336
2025	4	8	3	12	55	0.74	96.1	77.5853	53.8162
2025	4	8	3	22	55	0.75	95.5	77.5853	54.7815
2025	4	8	3	32	55	0.74	95.3	77.5853	54.2989
2025	4	8	3	42	55	0.74	98.7	77.5853	53.5749
2025	4	8	3	52	55	0.73	98.1	77.5853	52.8509
2025	4	8	4	2	55	0.72	97.1	77.5853	52.6096
2025	4	8	4	12	55	0.73	99.9	77.5853	52.6096
2025	4	8	4	22	55	0.77	99.5	77.5853	55.9882
2025	4	8	4	32	55	0.75	95.3	77.5197	54.7331
2025	4	8	4	42	55	0.71	97.4	77.5197	52.0808
2025	4	8	4	52	55	0.71	95.6	77.5197	51.8397
2025	4	8	5	2	55	0.72	96.5	77.5197	52.8042
2025	4	8	5	12	55	0.79	95.5	77.5197	57.6265
2025	4	8	5	22	55	0.72	96.3	77.5197	52.8042
2025	4	8	5	32	55	0.7	99.7	77.5197	50.8752
2025	4	8	5	42	55	0.74	97.2	77.4541	53.721
2025	4	8	5	52	55	0.74	98.2	77.4541	53.721
2025	4	8	6	2	55	0.77	97.6	77.4541	55.8891
2025	4	8	6	12	55	0.73	98.6	77.4541	52.7574
2025	4	8	6	22	55	0.72	95.2	77.4541	52.7574
2025	4	8	6	32	55	0.7	96.7	77.4541	51.3119
2025	4	8	6	42	55	0.72	96.8	77.4541	52.2755
2025	4	8	6	52	55	0.7	98.3	77.4541	51.071
2025	4	8	7	2	55	0.72	95.2	77.4541	52.7573
2025	4	8	7	12	55	0.75	97.6	77.4541	54.4436
2025	4	8	7	22	55	0.73	95.7	77.4541	53.4799
2025	4	8	7	32	55	0.72	97.6	77.3885	52.2291
2025	4	8	7	42	55	0.73	98	77.4541	52.9981
2025	4	8	7	52	55	0.7	97	77.3885	50.785

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	8	8	2	55	0.73	97	77.4541	53.2389
2025	4	8	8	12	55	0.7	100.2	77.4541	50.8299
2025	4	8	8	22	55	0.73	95.7	77.4541	53.4797
2025	4	8	8	32	55	0.72	96.3	77.4541	52.2751
2025	4	8	8	42	55	0.74	98.7	77.4541	53.4796
2025	4	8	8	52	55	0.74	96.8	77.4541	54.2022
2025	4	8	9	2	55	0.74	95.1	77.4541	54.4431
2025	4	8	9	12	55	0.74	99.7	77.4541	53.7203
2025	4	8	9	22	55	0.72	97.1	77.4541	52.2748
2025	4	8	9	32	55	0.72	96.3	77.4541	52.7566
2025	4	8	9	42	55	0.71	96.3	77.5197	52.0799
2025	4	8	9	52	55	0.71	97.1	77.5197	52.0799
2025	4	8	10	2	55	0.7	97.5	77.4541	51.311
2025	4	8	10	12	55	0.73	97.7	77.4541	53.479
2025	4	8	10	22	55	0.74	95.4	77.4541	53.9608
2025	4	8	10	32	55	0.71	98.7	77.4541	51.7926
2025	4	8	10	42	55	0.75	99.1	77.5197	54.2496
2025	4	8	10	52	55	0.74	99	77.4541	53.4788
2025	4	8	11	2	55	0.74	96.9	77.5197	54.0083
2025	4	8	11	12	55	0.73	98.6	77.5197	52.8027
2025	4	8	11	22	55	0.7	97	77.5197	50.8738
2025	4	8	11	32	55	0.73	94.6	77.5197	53.5259
2025	4	8	11	42	55	0.74	100	77.4541	53.2376
2025	4	8	11	52	55	0.73	97.5	77.5197	53.0436
2025	4	8	12	2	55	0.7	94.9	77.5197	51.1147
2025	4	8	12	12	55	0.71	98.5	77.4541	51.5512
2025	4	8	12	22	55	0.7	99.4	77.5197	51.1146
2025	4	8	12	32	55	0.7	96.2	77.5197	51.3556
2025	4	8	12	42	55	0.72	96	77.5853	52.6076
2025	4	8	12	52	55	0.71	98.5	77.5853	51.6423
2025	4	8	13	2	55	0.73	98.3	77.5197	53.0432
2025	4	8	13	12	55	0.73	98.6	77.5197	52.8021
2025	4	8	13	22	55	0.73	96.9	77.4541	53.478
2025	4	8	13	32	55	0.7	95.6	77.4541	51.3099
2025	4	8	13	42	55	0.73	96.7	77.5853	53.09
2025	4	8	13	52	55	0.76	95.7	77.5853	55.2618
2025	4	8	14	2	55	0.74	95.1	77.5197	54.4896
2025	4	8	14	12	55	0.73	97	77.3885	53.1897
2025	4	8	14	22	55	0.72	97.1	77.3885	52.4676
2025	4	8	14	32	55	0.72	97.3	77.3885	52.4676
2025	4	8	14	42	55	0.74	97.9	77.3885	53.4303
2025	4	8	14	52	55	0.76	98.2	77.3228	55.0661
2025	4	8	15	2	55	0.71	96.1	77.3885	51.7455
2025	4	8	15	12	55	0.74	96.6	77.3885	54.1522
2025	4	8	15	22	55	0.77	97.9	77.3885	55.8369
2025	4	8	15	32	55	0.69	96	77.3885	50.542
2025	4	8	15	42	55	0.7	95.7	77.3885	51.0234
2025	4	8	15	52	55	0.73	96.7	77.3885	52.9487

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	8	16	2	55	0.75	96.8	77.3885	54.3928
2025	4	8	16	12	55	0.71	98.5	77.3228	51.459
2025	4	8	16	22	55	0.74	96.4	77.3885	53.9114
2025	4	8	16	32	55	0.7	98.1	77.3228	50.7376
2025	4	8	16	42	55	0.75	95.3	77.3228	54.8254
2025	4	8	16	52	55	0.72	97.3	77.3228	52.4208
2025	4	8	17	2	55	0.69	97.9	77.3228	50.2567
2025	4	8	17	12	55	0.72	100.3	77.3228	51.6994
2025	4	8	17	22	55	0.71	98.5	77.3228	51.2185
2025	4	8	17	32	55	0.68	94.7	77.3228	50.0162
2025	4	8	17	42	55	0.71	96.4	77.3228	51.459
2025	4	8	17	52	55	0.72	96.5	77.3228	52.4208
2025	4	8	18	2	55	0.78	97	77.3228	56.9896
2025	4	8	18	12	55	0.66	97.4	77.3228	48.333
2025	4	8	18	22	55	0.74	95.6	77.3228	54.3446
2025	4	8	18	32	55	0.77	96.6	77.3228	55.7873
2025	4	8	18	42	55	0.72	94.9	77.3228	52.9018
2025	4	8	18	52	55	0.71	95.3	77.3228	51.94
2025	4	8	19	2	55	0.73	99.3	77.3228	52.9019
2025	4	8	19	12	55	0.74	97.7	77.3228	53.6233
2025	4	8	19	22	55	0.71	93.4	77.3228	52.1805
2025	4	8	19	32	55	0.74	95.6	77.3228	53.8638
2025	4	8	19	42	55	0.73	95.4	77.3228	53.3829
2025	4	8	19	52	55	0.76	97.7	77.3228	55.0662
2025	4	8	20	2	55	0.74	98.2	77.2572	53.3356
2025	4	8	20	12	55	0.72	94.9	77.3228	52.9021
2025	4	8	20	22	55	0.72	98.1	77.3228	52.4212
2025	4	8	20	32	55	0.71	97.4	77.3228	51.9403
2025	4	8	20	42	55	0.72	100.8	77.3228	51.6999
2025	4	8	20	52	55	0.76	99.1	77.2572	55.2578
2025	4	8	21	2	55	0.73	95.7	77.3228	53.3832
2025	4	8	21	12	55	0.73	96.2	77.3228	52.9023
2025	4	8	21	22	55	0.73	94.4	77.3228	53.3833
2025	4	8	21	32	55	0.7	97.5	77.3228	51.2192
2025	4	8	21	42	55	0.68	98.4	77.3885	49.0986
2025	4	8	21	52	55	0.76	97.7	77.4541	55.4054
2025	4	8	22	2	55	0.74	96.1	77.4541	53.7192
2025	4	8	22	12	55	0.7	97.2	77.4541	51.3103
2025	4	8	22	22	55	0.75	97.5	77.4541	54.6829
2025	4	8	22	32	55	0.74	97.9	77.4541	53.4784
2025	4	8	22	42	55	0.71	94.8	77.4541	52.0331
2025	4	8	22	52	55	0.69	98.2	77.4541	50.3469
2025	4	8	23	2	55	0.69	97.4	77.4541	50.347
2025	4	8	23	12	55	0.69	96.5	77.4541	50.5879
2025	4	8	23	22	55	0.67	96.7	77.4541	48.9017
2025	4	8	23	32	55	0.7	96.2	77.4541	50.8289
2025	4	8	23	42	55	0.69	96	77.4541	50.588
2025	4	8	23	52	55	0.67	99.8	77.4541	48.6609

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	9	0	2	55	0.69	97.1	77.4541	50.1063
2025	4	9	0	12	55	0.71	97.9	77.4541	51.7926
2025	4	9	0	22	55	0.7	97	77.4541	50.8291
2025	4	9	0	32	55	0.7	95.9	77.4541	51.3109
2025	4	9	0	42	55	0.69	97.1	77.4541	50.1064
2025	4	9	0	52	55	0.72	95.8	77.4541	52.2745
2025	4	9	1	2	55	0.72	94.7	77.4541	52.5154
2025	4	9	1	12	55	0.74	96.3	77.4541	54.2017
2025	4	9	1	22	55	0.72	95.2	77.4541	52.5155
2025	4	9	1	32	55	0.72	97.3	77.4541	52.5155
2025	4	9	1	42	55	0.69	97.4	77.4541	50.3475
2025	4	9	1	52	55	0.73	95.7	77.4541	52.9973
2025	4	9	2	2	55	0.68	93.6	77.4541	49.8657
2025	4	9	2	12	55	0.73	93.4	77.4541	53.2383
2025	4	9	2	22	55	0.74	94.3	77.4541	54.2019
2025	4	9	2	32	55	0.74	95.9	77.4541	53.7201
2025	4	9	2	42	55	0.7	94.8	77.4541	51.3111
2025	4	9	2	52	55	0.72	94.7	77.4541	52.5156
2025	4	9	3	2	55	0.7	95.9	77.4541	51.3111
2025	4	9	3	12	55	0.7	94.3	77.4541	51.3112
2025	4	9	3	22	55	0.71	94	77.4541	51.793
2025	4	9	3	32	55	0.7	94.8	77.4541	51.3112
2025	4	9	3	42	55	0.69	96	77.4541	50.1067
2025	4	9	3	52	55	0.73	96.4	77.4541	53.4792
2025	4	9	4	2	55	0.7	96.2	77.4541	51.3112
2025	4	9	4	12	55	0.73	96.9	77.4541	53.4792
2025	4	9	4	22	55	0.72	95.2	77.4541	52.5157
2025	4	9	4	32	55	0.71	96.6	77.4541	51.793
2025	4	9	4	42	55	0.71	96.3	77.4541	52.0338
2025	4	9	4	52	55	0.76	96.9	77.4541	55.4064
2025	4	9	5	2	55	0.73	96.9	77.4541	53.4792
2025	4	9	5	12	55	0.71	94.5	77.4541	51.7929
2025	4	9	5	22	55	0.73	95.1	77.4541	53.7201
2025	4	9	5	32	55	0.76	96.9	77.4541	55.6473
2025	4	9	5	42	55	0.77	97.1	77.4541	55.8882
2025	4	9	5	52	55	0.72	97.6	77.4541	52.0338
2025	4	9	6	2	55	0.75	96.6	77.4541	54.4428
2025	4	9	6	12	55	0.7	97.3	77.4541	50.8293
2025	4	9	6	22	55	0.72	97.3	77.3885	52.469
2025	4	9	6	32	55	0.74	96.9	77.3885	53.9131
2025	4	9	6	42	55	0.68	97.4	77.3885	49.8215
2025	4	9	6	52	55	0.7	97.6	77.3885	50.5435
2025	4	9	7	2	55	0.73	97.3	77.3885	52.9503
2025	4	9	7	12	55	0.76	96.4	77.3885	55.5978
2025	4	9	7	22	55	0.75	95.5	77.3885	54.6351
2025	4	9	7	32	55	0.75	99.1	77.3885	54.3943
2025	4	9	7	42	55	0.75	94.3	77.3885	54.635
2025	4	9	7	52	55	0.78	95.8	77.3885	56.8011

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	9	8	2	55	0.76	95.2	77.3885	55.5976
2025	4	9	8	12	55	0.73	97.5	77.3885	53.1907
2025	4	9	8	22	55	0.76	97.7	77.3228	55.0672
2025	4	9	8	32	55	0.74	98.6	77.3228	53.8649
2025	4	9	8	42	55	0.74	98.5	77.3228	53.3839
2025	4	9	8	52	55	0.7	100.5	77.2572	50.4534
2025	4	9	9	2	55	0.75	96.8	77.2572	54.7779
2025	4	9	9	12	55	0.75	96.6	77.1916	54.2491
2025	4	9	9	22	55	0.78	95.5	77.1916	56.8895
2025	4	9	9	32	55	0.7	98.6	77.1916	50.8884
2025	4	9	9	42	55	0.73	96.5	77.1916	53.0487
2025	4	9	9	52	55	0.71	97.2	77.1916	51.3684
2025	4	9	10	2	55	0.72	95.7	77.1916	52.5685
2025	4	9	10	12	55	0.73	94.9	77.1916	53.5286
2025	4	9	10	22	55	0.69	95.7	77.1916	50.4081
2025	4	9	10	32	55	0.73	99.3	77.1916	52.8084
2025	4	9	10	42	55	0.71	97.7	77.2572	51.654
2025	4	9	10	52	55	0.69	94.9	77.1916	50.4079
2025	4	9	11	2	55	0.7	96	77.1916	50.6479
2025	4	9	11	12	55	0.72	98.6	77.1916	52.3281
2025	4	9	11	22	55	0.71	98.2	77.1916	51.3679
2025	4	9	11	32	55	0.74	94.3	77.2572	53.816
2025	4	9	11	42	55	0.7	100.5	77.2572	50.4524
2025	4	9	11	52	55	0.71	97.4	77.1916	51.8478
2025	4	9	12	2	55	0.74	95.9	77.1916	53.768
2025	4	9	12	12	55	0.7	96.8	77.1916	50.6475
2025	4	9	12	22	55	0.68	97.5	77.1916	49.4473
2025	4	9	12	32	55	0.73	97	77.1916	53.0477
2025	4	9	12	42	55	0.68	98.1	77.1916	48.9671
2025	4	9	12	52	55	0.7	96.2	77.1916	50.6473
2025	4	9	13	2	55	0.71	97.4	77.1916	51.8474
2025	4	9	13	12	55	0.7	96.5	77.1916	50.6472
2025	4	9	13	22	55	0.7	94	77.2572	51.1727
2025	4	9	13	32	55	0.72	95.5	77.1916	52.0873
2025	4	9	13	42	55	0.73	99.9	77.1916	52.3273
2025	4	9	13	52	55	0.7	95.9	77.1916	50.8871
2025	4	9	14	2	55	0.73	95.7	77.2572	53.3347
2025	4	9	14	12	55	0.74	94.8	77.1916	54.0074
2025	4	9	14	22	55	0.71	97.9	77.1916	51.6071
2025	4	9	14	32	55	0.67	99.2	77.1916	48.7266
2025	4	9	14	42	55	0.74	97.4	77.1916	53.7673
2025	4	9	14	52	55	0.73	96.4	77.126	53.2398
2025	4	9	15	2	55	0.71	96.1	77.1916	51.6069
2025	4	9	15	12	55	0.69	96.3	77.126	50.1221
2025	4	9	15	22	55	0.71	98	77.1916	51.1268
2025	4	9	15	32	55	0.7	97.6	77.1916	50.4067
2025	4	9	15	42	55	0.7	97.6	77.126	50.3619
2025	4	9	15	52	55	0.71	96.3	77.126	51.8008

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	9	16	2	55	0.75	98.5	77.126	54.4388
2025	4	9	16	12	55	0.7	99.5	77.126	50.3618
2025	4	9	16	22	55	0.74	98.2	77.126	53.2396
2025	4	9	16	32	55	0.72	96	77.126	52.5202
2025	4	9	16	42	55	0.72	97.1	77.0604	51.9942
2025	4	9	16	52	55	0.69	95.4	77.0604	50.317
2025	4	9	17	2	55	0.72	97.4	77.126	52.0406
2025	4	9	17	12	55	0.71	98.5	77.126	51.5609
2025	4	9	17	22	55	0.75	96	77.1916	54.4872
2025	4	9	17	32	55	0.73	96.4	77.126	53.2397
2025	4	9	17	42	55	0.73	98.3	77.126	52.76
2025	4	9	17	52	55	0.71	98.2	77.126	51.3211
2025	4	9	18	2	55	0.74	97.1	77.126	53.9591
2025	4	9	18	12	55	0.74	97.4	77.126	53.7193
2025	4	9	18	22	55	0.73	94.7	77.126	52.9999
2025	4	9	18	32	55	0.73	97	77.126	52.7601
2025	4	9	18	42	55	0.72	100	77.126	51.8008
2025	4	9	18	52	55	0.71	96.3	77.126	51.8008
2025	4	9	19	2	55	0.71	98	77.126	51.0814
2025	4	9	19	12	55	0.72	96	77.0604	52.234
2025	4	9	19	22	55	0.68	95.3	77.0604	49.3588
2025	4	9	19	32	55	0.73	97.2	77.0604	52.9529
2025	4	9	19	42	55	0.71	94.5	77.0604	51.9945
2025	4	9	19	52	55	0.72	97.6	77.0604	51.7549
2025	4	9	20	2	55	0.75	97.6	77.0604	54.151
2025	4	9	20	12	55	0.74	97.4	77.0604	53.6718
2025	4	9	20	22	55	0.7	98.8	77.0604	50.7966
2025	4	9	20	32	55	0.71	97.1	77.0604	51.7551
2025	4	9	20	42	55	0.7	94.6	77.0604	51.0363
2025	4	9	20	52	55	0.7	97.8	77.0604	50.7967
2025	4	9	21	2	55	0.7	95.7	77.0604	50.5572
2025	4	9	21	12	55	0.73	95.4	77.0604	53.1929
2025	4	9	21	22	55	0.75	99.8	77.0604	53.9117
2025	4	9	21	32	55	0.73	95.9	77.0604	52.9534
2025	4	9	21	42	55	0.72	97.6	76.9948	51.9487
2025	4	9	21	52	55	0.72	97.9	76.9948	51.7093
2025	4	9	22	2	55	0.71	96.9	76.9948	51.47
2025	4	9	22	12	55	0.71	98.5	76.9948	51.47
2025	4	9	22	22	55	0.74	97.1	76.9948	53.6246
2025	4	9	22	32	55	0.7	96.2	76.9948	50.7519
2025	4	9	22	42	55	0.71	96.1	76.9948	51.2307
2025	4	9	22	52	55	0.71	96.7	76.9948	51.2308
2025	4	9	23	2	55	0.7	100	76.9948	50.0338
2025	4	9	23	12	55	0.72	95.8	76.9948	52.1884
2025	4	9	23	22	55	0.68	97.5	76.9948	49.3157
2025	4	9	23	32	55	0.71	95.3	76.9948	51.2309
2025	4	9	23	42	55	0.73	95.5	76.9948	52.6673
2025	4	9	23	52	55	0.71	98.8	76.9948	50.9916

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	10	0	2	55	0.73	95.7	76.9948	53.1462
2025	4	10	0	12	55	0.74	96.7	76.9948	53.3856
2025	4	10	0	22	55	0.76	95.9	76.9948	55.3009
2025	4	10	0	32	55	0.72	98.4	76.9291	52.1422
2025	4	10	0	42	55	0.76	94.5	76.9948	55.0615
2025	4	10	0	52	55	0.72	96.8	76.9291	51.9031
2025	4	10	1	2	55	0.69	98	76.9291	49.5113
2025	4	10	1	12	55	0.73	95.7	76.9291	53.0991
2025	4	10	1	22	55	0.73	100.1	76.9291	52.1423
2025	4	10	1	32	55	0.7	97.3	76.9291	50.4681
2025	4	10	1	42	55	0.71	99.6	76.9291	50.9464
2025	4	10	1	52	55	0.7	95.1	76.9291	50.9465
2025	4	10	2	2	55	0.76	95.7	76.9291	55.0126
2025	4	10	2	12	55	0.69	96.5	76.9291	50.2289
2025	4	10	2	22	55	0.73	96.4	76.9291	53.0992
2025	4	10	2	32	55	0.72	97	76.9291	52.3816
2025	4	10	2	42	55	0.75	99.3	76.9291	53.8168
2025	4	10	2	52	55	0.7	97.5	76.9291	50.9465
2025	4	10	3	2	55	0.73	97.3	76.9291	52.6208
2025	4	10	3	12	55	0.71	98.3	76.9291	50.9466
2025	4	10	3	22	55	0.72	97.1	76.9291	51.9033
2025	4	10	3	32	55	0.7	95.7	76.9291	50.7074
2025	4	10	3	42	55	0.73	95.9	76.9291	52.8601
2025	4	10	3	52	55	0.73	99.1	76.9291	52.3817
2025	4	10	4	2	55	0.73	94.7	76.9291	52.8601
2025	4	10	4	12	55	0.76	96.4	76.9291	55.0127
2025	4	10	4	22	55	0.72	97	76.9291	52.3817
2025	4	10	4	32	55	0.73	96.5	76.9291	52.86
2025	4	10	4	42	55	0.7	96	76.9291	50.4682
2025	4	10	4	52	55	0.75	97.7	76.9291	54.5343
2025	4	10	5	2	55	0.74	96.1	76.9291	53.3384
2025	4	10	5	12	55	0.69	98.7	76.9291	49.9898
2025	4	10	5	22	55	0.74	95.9	76.8635	53.5298
2025	4	10	5	32	55	0.72	96.1	76.9291	51.9033
2025	4	10	5	42	55	0.72	98.4	76.8635	51.618
2025	4	10	5	52	55	0.7	96.2	76.9291	50.9465
2025	4	10	6	2	55	0.72	100.3	76.9291	51.4249
2025	4	10	6	12	55	0.72	97.3	76.9291	52.3816
2025	4	10	6	22	55	0.69	96.5	76.8635	50.1841
2025	4	10	6	32	55	0.7	95.4	76.9291	50.4681
2025	4	10	6	42	55	0.74	96.6	76.9291	53.8167
2025	4	10	6	52	55	0.76	96.7	76.9291	55.2518
2025	4	10	7	2	55	0.72	98.1	76.9291	51.9032
2025	4	10	7	12	55	0.72	98.4	76.9291	52.1423
2025	4	10	7	22	55	0.72	96.3	76.9291	51.9031
2025	4	10	7	32	55	0.73	96.7	76.9291	53.099
2025	4	10	7	42	55	0.69	96.5	76.9291	50.2287
2025	4	10	7	52	55	0.69	95.2	76.9291	50.2287

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	10	8	2	55	0.72	95.2	76.9291	52.1421
2025	4	10	8	12	55	0.73	94.1	76.9291	53.0988
2025	4	10	8	22	55	0.72	98.4	76.9291	52.142
2025	4	10	8	32	55	0.71	96.9	76.9291	51.1852
2025	4	10	8	42	55	0.72	96.5	76.9291	52.1419
2025	4	10	8	52	55	0.71	99	76.9291	51.1851
2025	4	10	9	2	55	0.71	95.3	76.9291	51.6634
2025	4	10	9	12	55	0.69	96.3	76.9291	49.9891
2025	4	10	9	22	55	0.73	100.4	76.9291	52.1417
2025	4	10	9	32	55	0.62	96.3	76.9291	45.2053
2025	4	10	9	42	55	0.72	97.3	76.9291	52.3807
2025	4	10	9	52	55	0.69	97.7	76.9291	49.7497
2025	4	10	10	2	55	0.7	96	76.8635	50.4221
2025	4	10	10	12	55	0.72	99.5	76.7979	51.5708
2025	4	10	10	22	55	0.68	95.8	76.7323	49.1393
2025	4	10	10	32	55	0.7	95.9	76.7979	50.8545
2025	4	10	10	42	55	0.67	96.7	76.7979	48.7056
2025	4	10	10	52	55	0.69	96.3	76.7979	50.1381
2025	4	10	11	2	55	0.7	96.5	76.7323	50.3318
2025	4	10	11	12	55	0.74	96.1	76.7979	53.4805
2025	4	10	11	22	55	0.69	96.3	76.7979	49.6604
2025	4	10	11	32	55	0.71	97.5	76.7979	51.0929
2025	4	10	11	42	55	0.67	98.1	76.7979	48.4666
2025	4	10	11	52	55	0.72	97.6	76.7323	52.0013
2025	4	10	12	2	55	0.67	96.8	76.7979	48.2277
2025	4	10	12	12	55	0.71	99.1	76.7979	50.854
2025	4	10	12	22	55	0.69	98.5	76.7979	49.6602
2025	4	10	12	32	55	0.7	99.2	76.7979	50.3764
2025	4	10	12	42	55	0.67	97.3	76.7979	48.4663
2025	4	10	12	52	55	0.71	98.5	76.7979	51.3313
2025	4	10	13	2	55	0.74	98.5	76.7979	53.0025
2025	4	10	13	12	55	0.71	96.4	76.7979	51.3312
2025	4	10	13	22	55	0.71	97.8	76.7979	50.8536
2025	4	10	13	32	55	0.69	93.5	76.7979	50.1373
2025	4	10	13	42	55	0.68	98.6	76.7979	49.1823
2025	4	10	13	52	55	0.72	95.5	76.7323	52.0007
2025	4	10	14	2	55	0.68	96.9	76.7979	49.421
2025	4	10	14	12	55	0.7	96.8	76.7979	50.3759
2025	4	10	14	22	55	0.72	99.8	76.7979	51.3309
2025	4	10	14	32	55	0.69	97.1	76.7979	49.6597
2025	4	10	14	42	55	0.69	97.1	76.7979	50.1371
2025	4	10	14	52	55	0.71	95.3	76.7979	51.0921
2025	4	10	15	2	55	0.72	96	76.7979	52.0471
2025	4	10	15	12	55	0.75	96.8	76.7979	53.957
2025	4	10	15	22	55	0.71	95.3	76.7979	51.5695
2025	4	10	15	32	55	0.72	95.5	76.7979	52.047
2025	4	10	15	42	55	0.73	98.6	76.7979	52.2857
2025	4	10	15	52	55	0.73	96.2	76.7979	53.002

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	10	16	2	55	0.71	95.6	76.7979	51.3307
2025	4	10	16	12	55	0.71	97.7	76.7979	51.3307
2025	4	10	16	22	55	0.72	98.6	76.7979	51.8082
2025	4	10	16	32	55	0.71	95.8	76.7979	51.5694
2025	4	10	16	42	55	0.67	95.1	76.7979	48.4657
2025	4	10	16	52	55	0.73	94.9	76.7979	53.0019
2025	4	10	17	2	55	0.72	97.6	76.7979	51.5695
2025	4	10	17	12	55	0.69	97.1	76.7979	50.137
2025	4	10	17	22	55	0.73	96.9	76.7979	53.002
2025	4	10	17	32	55	0.7	97.3	76.7979	50.6145
2025	4	10	17	42	55	0.74	94.6	76.7979	53.7182
2025	4	10	17	52	55	0.74	99.5	76.7979	52.7632
2025	4	10	18	2	55	0.74	96.1	76.8635	53.2883
2025	4	10	18	12	55	0.69	94.1	76.8635	50.4208
2025	4	10	18	22	55	0.72	97.9	76.8635	51.8546
2025	4	10	18	32	55	0.71	95.3	76.8635	51.6157
2025	4	10	18	42	55	0.73	96	76.8635	52.5715
2025	4	10	18	52	55	0.69	96.3	76.8635	49.704
2025	4	10	19	2	55	0.68	98.9	76.8635	48.7482
2025	4	10	19	12	55	0.73	96	76.8635	52.5716
2025	4	10	19	22	55	0.72	97	76.8635	52.3327
2025	4	10	19	32	55	0.75	97.2	76.9291	54.532
2025	4	10	19	42	55	0.71	97.2	76.9291	51.4228
2025	4	10	19	52	55	0.72	96.1	76.8635	51.8548
2025	4	10	20	2	55	0.69	96.3	76.9291	49.9878
2025	4	10	20	12	55	0.7	96	76.9291	50.4662
2025	4	10	20	22	55	0.71	96.9	76.9291	51.6621
2025	4	10	20	32	55	0.71	94.8	76.9948	51.7082
2025	4	10	20	42	55	0.71	96.6	76.9948	51.4689
2025	4	10	20	52	55	0.72	93.1	77.0604	52.7128
2025	4	10	21	2	55	0.74	96.4	77.126	53.7191
2025	4	10	21	12	55	0.69	95.2	77.126	49.882
2025	4	10	21	22	55	0.7	97.6	77.1916	50.4065
2025	4	10	21	32	55	0.71	96.6	77.1916	51.6067
2025	4	10	21	42	55	0.74	98.4	77.1916	53.527
2025	4	10	21	52	55	0.75	98.1	77.1916	54.2471
2025	4	10	22	2	55	0.72	96.8	77.2572	52.3734
2025	4	10	22	12	55	0.68	97	77.2572	49.2503
2025	4	10	22	22	55	0.78	96.1	77.2572	56.4577
2025	4	10	22	32	55	0.77	96.3	77.2572	56.2175
2025	4	10	22	42	55	0.74	96.8	77.2572	54.0553
2025	4	10	22	52	55	0.73	95.9	77.3228	53.382
2025	4	10	23	2	55	0.73	96.7	77.3228	53.3821
2025	4	10	23	12	55	0.73	97.8	77.3228	52.9012
2025	4	10	23	22	55	0.7	95.1	77.3228	51.4584
2025	4	10	23	32	55	0.69	98.4	77.3228	50.2562
2025	4	10	23	42	55	0.76	98.4	77.3228	55.3059
2025	4	10	23	52	55	0.75	97.3	77.3228	54.5845

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	11	0	2	55	0.75	96.8	77.3228	54.3441
2025	4	11	0	12	55	0.71	95.6	77.3228	51.9396
2025	4	11	0	22	55	0.76	97.4	77.3885	55.5958
2025	4	11	0	32	55	0.74	95.6	77.3885	54.3925
2025	4	11	0	42	55	0.74	96.4	77.3885	53.6705
2025	4	11	0	52	55	0.74	98.1	77.3885	53.9112
2025	4	11	1	2	55	0.7	97	77.3885	51.0231
2025	4	11	1	12	55	0.72	97.6	77.4541	52.2728
2025	4	11	1	22	55	0.73	95.4	77.5197	53.5247
2025	4	11	1	32	55	0.71	96.6	77.5853	52.1242
2025	4	11	1	42	55	0.75	96.8	77.6509	54.8271
2025	4	11	1	52	55	0.73	98.3	77.7165	53.1834
2025	4	11	2	2	55	0.75	96.3	77.7165	55.1173
2025	4	11	2	12	55	0.72	97.8	77.7165	52.6999
2025	4	11	2	22	55	0.74	95.9	77.7822	53.9562
2025	4	11	2	32	55	0.76	95.2	77.7822	56.1339
2025	4	11	2	42	55	0.72	97.4	77.7822	52.5045
2025	4	11	2	52	55	0.78	98.5	77.8478	56.6677
2025	4	11	3	2	55	0.77	95.4	77.8478	56.6677
2025	4	11	3	12	55	0.71	97.4	77.8478	52.3087
2025	4	11	3	22	55	0.76	97.7	77.9134	55.5058
2025	4	11	3	32	55	0.72	97.8	77.9134	52.8396
2025	4	11	3	42	55	0.73	96.7	77.9134	53.8091
2025	4	11	3	52	55	0.69	97.7	77.9134	50.1734
2025	4	11	4	2	55	0.74	96.1	77.9134	54.2939
2025	4	11	4	12	55	0.75	98.1	77.9134	54.7787
2025	4	11	4	22	55	0.74	95.6	77.9134	54.0515
2025	4	11	4	32	55	0.74	95.9	77.9134	54.0515
2025	4	11	4	42	55	0.72	97.3	77.979	52.8861
2025	4	11	4	52	55	0.77	99.3	77.979	56.0399
2025	4	11	5	2	55	0.74	95.6	77.979	54.0991
2025	4	11	5	12	55	0.74	95.6	78.0446	54.8751
2025	4	11	5	22	55	0.73	96.7	78.0446	53.4183
2025	4	11	5	32	55	0.83	95	78.0446	60.9454
2025	4	11	5	42	55	0.73	95.4	78.0446	53.9039
2025	4	11	5	52	55	0.78	98.4	78.0446	57.3032
2025	4	11	6	2	55	0.74	96.6	78.1102	54.4373
2025	4	11	6	12	55	0.79	96.7	78.1102	57.8396
2025	4	11	6	22	55	0.76	97.4	78.1102	56.1385
2025	4	11	6	32	55	0.76	97	78.1758	55.7013
2025	4	11	6	42	55	0.78	95.3	78.1758	57.8904
2025	4	11	6	52	55	0.75	95.5	78.2415	55.5067
2025	4	11	7	2	55	0.76	96.7	78.3071	56.2863
2025	4	11	7	12	55	0.71	96.1	78.3727	52.4336
2025	4	11	7	22	55	0.7	96.2	78.4383	51.5031
2025	4	11	7	32	55	0.77	96.6	78.4383	56.873
2025	4	11	7	42	55	0.71	97.1	78.5039	52.7696
2025	4	11	7	52	55	0.76	96.2	78.5039	56.1898

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	11	8	2	55	0.74	96.1	78.5039	54.7239
2025	4	11	8	12	55	0.77	95.6	78.5696	57.4614
2025	4	11	8	22	55	0.74	98.6	78.5696	54.7717
2025	4	11	8	32	55	0.77	98.1	78.5696	56.4832
2025	4	11	8	42	55	0.8	96.6	78.6352	58.9798
2025	4	11	8	52	55	0.77	93.9	78.6352	57.2666
2025	4	11	9	2	55	0.75	98.8	78.6352	55.3088
2025	4	11	9	12	55	0.77	96.8	78.7008	57.3165
2025	4	11	9	22	55	0.72	93.7	78.7008	53.3974
2025	4	11	9	32	55	0.78	95.3	78.7008	58.2962
2025	4	11	9	42	55	0.75	97.8	78.7664	55.4051
2025	4	11	9	52	55	0.77	97.8	78.7664	57.1211
2025	4	11	10	2	55	0.75	97.3	78.7664	55.6501
2025	4	11	10	12	55	0.78	98.3	78.832	57.4161
2025	4	11	10	22	55	0.72	96.3	78.832	53.7355
2025	4	11	10	32	55	0.76	96.4	78.832	56.6798
2025	4	11	10	42	55	0.76	98	78.8976	56.238
2025	4	11	10	52	55	0.75	98.3	78.832	55.2075
2025	4	11	11	2	55	0.75	96.6	78.8976	55.5011
2025	4	11	11	12	55	0.79	97.4	78.9633	58.4988
2025	4	11	11	22	55	0.78	95.5	78.9633	58.253
2025	4	11	11	32	55	0.75	97.7	78.9633	56.0408
2025	4	11	11	42	55	0.74	99.4	78.9633	55.0575
2025	4	11	11	52	55	0.73	96.2	78.9633	54.0743
2025	4	11	12	2	55	0.72	96.5	78.9633	53.8285
2025	4	11	12	12	55	0.72	96.8	79.0289	53.6292
2025	4	11	12	22	55	0.74	94.6	79.0289	55.5972
2025	4	11	12	32	55	0.75	96.8	79.0289	55.5971
2025	4	11	12	42	55	0.76	97.4	79.0945	56.8764
2025	4	11	12	52	55	0.74	95.3	79.0289	55.597
2025	4	11	13	2	55	0.75	96.5	79.0945	56.1377
2025	4	11	13	12	55	0.75	97.6	79.0945	55.6452
2025	4	11	13	22	55	0.73	100.7	79.0945	53.6754
2025	4	11	13	32	55	0.75	98.3	79.1601	55.447
2025	4	11	13	42	55	0.74	97.3	79.1601	55.4469
2025	4	11	13	52	55	0.8	97.6	79.1601	59.3898
2025	4	11	14	2	55	0.75	95.8	79.1601	55.9397
2025	4	11	14	12	55	0.75	96	79.1601	56.1861
2025	4	11	14	22	55	0.77	97.9	79.1601	57.1718
2025	4	11	14	32	55	0.78	97	79.2257	58.4545
2025	4	11	14	42	55	0.78	95.3	79.2257	58.4545
2025	4	11	14	52	55	0.78	98	79.2913	58.0114
2025	4	11	15	2	55	0.78	97.5	79.2257	57.9612
2025	4	11	15	12	55	0.77	97.6	79.2257	57.2213
2025	4	11	15	22	55	0.78	96.7	79.2913	58.5051
2025	4	11	15	32	55	0.75	94.3	79.2913	56.2833
2025	4	11	15	42	55	0.76	96.2	79.357	57.0732
2025	4	11	15	52	55	0.73	96.7	79.357	54.8496

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	11	16	2	55	0.76	93.7	79.4226	57.1226
2025	4	11	16	12	55	0.73	93.8	79.357	55.0967
2025	4	11	16	22	55	0.76	95.7	79.357	56.8262
2025	4	11	16	32	55	0.78	95.5	79.357	58.8027
2025	4	11	16	42	55	0.75	95	79.4226	56.628
2025	4	11	16	52	55	0.74	96.1	79.4226	55.1443
2025	4	11	17	2	55	0.76	98.2	79.4226	56.3808
2025	4	11	17	12	55	0.78	95.5	79.4226	58.6064
2025	4	11	17	22	55	0.78	96.8	79.4226	58.1118
2025	4	11	17	32	55	0.76	96.7	79.4226	57.1227
2025	4	11	17	42	55	0.82	94.3	79.4882	61.8745
2025	4	11	17	52	55	0.77	96.2	79.4882	57.4196
2025	4	11	18	2	55	0.78	96.5	79.4882	58.6571
2025	4	11	18	12	55	0.77	94.9	79.4882	57.9146
2025	4	11	18	22	55	0.75	96	79.5538	56.2307
2025	4	11	18	32	55	0.74	96.6	79.6851	55.8314
2025	4	11	18	42	55	0.76	97	79.6851	56.824
2025	4	11	18	52	55	0.78	93.8	79.6851	59.0573
2025	4	11	19	2	55	0.75	95.3	79.6851	56.5759
2025	4	11	19	12	55	0.78	97.7	79.6851	58.8092
2025	4	11	19	22	55	0.74	94.8	79.6851	55.8316
2025	4	11	19	32	55	0.75	95.3	79.6851	56.576
2025	4	11	19	42	55	0.77	95.9	79.6851	57.5686
2025	4	11	19	52	55	0.78	96.5	79.7507	58.86
2025	4	11	20	2	55	0.77	96.8	79.7507	58.115
2025	4	11	20	12	55	0.76	96.9	79.7507	57.1216
2025	4	11	20	22	55	0.78	96.8	79.7507	58.6118
2025	4	11	20	32	55	0.77	97.8	79.7507	58.1151
2025	4	11	20	42	55	0.77	98.1	79.8163	57.668
2025	4	11	20	52	55	0.81	96.5	79.7507	60.8471
2025	4	11	21	2	55	0.77	97.1	79.7507	58.1152
2025	4	11	21	12	55	0.74	96.1	79.7507	55.3834
2025	4	11	21	22	55	0.79	96.5	79.8163	59.1596
2025	4	11	21	32	55	0.78	96.8	79.8163	58.4139
2025	4	11	21	42	55	0.75	97	79.8163	56.674
2025	4	11	21	52	55	0.79	95.5	79.8163	59.6569
2025	4	11	22	2	55	0.78	94.8	79.8163	59.1598
2025	4	11	22	12	55	0.79	95	79.8819	59.4594
2025	4	11	22	22	55	0.8	96.1	79.8819	60.2058
2025	4	11	22	32	55	0.76	97.7	79.8819	56.9716
2025	4	11	22	42	55	0.81	95.4	79.8819	60.9522
2025	4	11	22	52	55	0.76	94.2	79.8819	57.2205
2025	4	11	23	2	55	0.81	95.8	79.8819	60.9523
2025	4	11	23	12	55	0.78	97.7	79.8819	58.7133
2025	4	11	23	22	55	0.81	98.1	79.9475	61.0047
2025	4	11	23	32	55	0.76	97.2	80.0131	57.5681
2025	4	11	23	42	55	0.78	94.6	80.0787	59.114
2025	4	11	23	52	55	0.81	96.3	80.1444	61.4114

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	12	0	2	55	0.77	97.3	80.1444	58.1662
2025	4	12	0	12	55	0.79	96.9	80.1444	59.664
2025	4	12	0	22	55	0.76	95.9	80.21	57.7163
2025	4	12	0	32	55	0.8	96.4	80.21	60.2148
2025	4	12	0	42	55	0.8	97	80.21	60.7146
2025	4	12	0	52	55	0.74	97.7	80.21	55.7175
2025	4	12	1	2	55	0.76	95	80.2756	57.5156
2025	4	12	1	12	55	0.83	98.6	80.2756	62.7671
2025	4	12	1	22	55	0.82	95.5	80.2756	62.2669
2025	4	12	1	32	55	0.8	97	80.2756	60.7666
2025	4	12	1	42	55	0.86	95.9	80.2756	65.5179
2025	4	12	1	52	55	0.79	96.4	80.3412	60.0676
2025	4	12	2	2	55	0.77	97.9	80.3412	57.8151
2025	4	12	2	12	55	0.82	94.6	80.3412	62.0699
2025	4	12	2	22	55	0.78	95.1	80.3412	59.3168
2025	4	12	2	32	55	0.78	96.5	80.3412	59.0665
2025	4	12	2	42	55	0.81	97.5	80.3412	61.0688
2025	4	12	2	52	55	0.78	96.5	80.3412	59.3168
2025	4	12	3	2	55	0.79	97.4	80.3412	59.8174
2025	4	12	3	12	55	0.79	95.7	80.3412	59.8174
2025	4	12	3	22	55	0.79	96.4	80.4068	59.8685
2025	4	12	3	32	55	0.78	95.8	80.4068	59.3675
2025	4	12	3	42	55	0.8	97.7	80.4068	60.8705
2025	4	12	3	52	55	0.82	97.8	80.4068	62.1229
2025	4	12	4	2	55	0.8	96.4	80.4724	60.6717
2025	4	12	4	12	55	0.8	97	80.4068	60.8705
2025	4	12	4	22	55	0.79	95.9	80.4068	60.119
2025	4	12	4	32	55	0.84	94.9	80.4724	64.1816
2025	4	12	4	42	55	0.8	96.3	80.4724	60.9224
2025	4	12	4	52	55	0.77	95.1	80.4724	58.9167
2025	4	12	5	2	55	0.8	98.3	80.4724	60.421
2025	4	12	5	12	55	0.78	95.5	80.4724	59.4181
2025	4	12	5	22	55	0.79	97.1	80.4724	60.1703
2025	4	12	5	32	55	0.81	96.3	80.5381	61.2253
2025	4	12	5	42	55	0.82	98.5	80.5381	62.229
2025	4	12	5	52	55	0.83	96.4	80.5381	62.9817
2025	4	12	6	2	55	0.79	95.2	80.5381	60.4725
2025	4	12	6	12	55	0.8	96.4	80.5381	60.7234
2025	4	12	6	22	55	0.78	98	80.5381	59.2179
2025	4	12	6	32	55	0.81	99.6	80.5381	60.7234
2025	4	12	6	42	55	0.79	97.4	80.6037	60.2728
2025	4	12	6	52	55	0.82	95.7	80.6037	62.533
2025	4	12	7	2	55	0.76	95.4	80.6693	58.0619
2025	4	12	7	12	55	0.76	97	80.6693	57.5592
2025	4	12	7	22	55	0.77	96.6	80.6693	58.5646
2025	4	12	7	32	55	0.78	94.8	80.6693	59.8213
2025	4	12	7	42	55	0.83	97.1	80.7349	62.8909
2025	4	12	7	52	55	0.79	96.4	80.6693	60.3239

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	12	8	2	55	0.82	97.4	80.7349	62.1361
2025	4	12	8	12	55	0.84	96.2	80.8005	64.4548
2025	4	12	8	22	55	0.81	97.4	80.8005	61.6852
2025	4	12	8	32	55	0.8	97	80.8005	61.1816
2025	4	12	8	42	55	0.79	95.9	80.8005	60.678
2025	4	12	8	52	55	0.78	98	80.8005	59.4191
2025	4	12	9	2	55	0.8	96.4	80.8005	60.6779
2025	4	12	9	12	55	0.82	96.9	80.8005	62.1885
2025	4	12	9	22	55	0.81	97.2	80.7349	61.381
2025	4	12	9	32	55	0.82	95.8	80.7349	62.3872
2025	4	12	9	42	55	0.77	97.6	80.7349	58.6137
2025	4	12	9	52	55	0.81	96.3	80.8661	61.7371
2025	4	12	10	2	55	0.78	98.2	80.8005	59.4187
2025	4	12	10	12	55	0.8	95.9	80.8005	60.9293
2025	4	12	10	22	55	0.8	97.5	80.8005	60.9293
2025	4	12	10	32	55	0.75	96.6	80.8005	56.9008
2025	4	12	10	42	55	0.78	95.3	80.8005	59.6703
2025	4	12	10	52	55	0.78	95.5	80.8661	59.9729
2025	4	12	11	2	55	0.78	95.8	80.8661	59.2168
2025	4	12	11	12	55	0.75	98	80.8005	57.1524
2025	4	12	11	22	55	0.8	98.8	80.8661	60.4767
2025	4	12	11	32	55	0.75	94.8	80.8661	57.4528
2025	4	12	11	42	55	0.79	94.5	80.8661	60.4766
2025	4	12	11	52	55	0.77	96.6	80.9318	59.0146
2025	4	12	12	2	55	0.75	93.7	80.8661	57.7046
2025	4	12	12	12	55	0.79	96.4	80.8661	60.4764
2025	4	12	12	22	55	0.75	96.5	80.8661	57.4525
2025	4	12	12	32	55	0.8	96.4	80.8661	60.9803
2025	4	12	12	42	55	0.8	96.6	80.9318	60.7798
2025	4	12	12	52	55	0.79	96.7	80.9318	60.5275
2025	4	12	13	2	55	0.78	97	80.9318	59.5187
2025	4	12	13	12	55	0.77	98.3	80.9318	58.762
2025	4	12	13	22	55	0.77	95.6	80.9318	59.2664
2025	4	12	13	32	55	0.79	96.9	80.9974	60.5786
2025	4	12	13	42	55	0.8	97.6	80.9318	60.7795
2025	4	12	13	52	55	0.81	99	80.9318	61.7883
2025	4	12	14	2	55	0.79	96.9	80.9974	60.0737
2025	4	12	14	12	55	0.77	96.1	80.9318	59.0141
2025	4	12	14	22	55	0.76	93	80.9974	58.3068
2025	4	12	14	32	55	0.83	97.3	80.9974	63.1026
2025	4	12	14	42	55	0.82	94.3	81.063	63.156
2025	4	12	14	52	55	0.79	96.7	80.9974	60.0736
2025	4	12	15	2	55	0.81	96.5	80.9974	61.5881
2025	4	12	15	12	55	0.82	96.2	81.063	62.6507
2025	4	12	15	22	55	0.84	96.3	81.063	64.1665
2025	4	12	15	32	55	0.79	96.9	81.063	60.6297
2025	4	12	15	42	55	0.79	95	81.063	60.6297
2025	4	12	15	52	55	0.8	94.2	81.063	61.6402

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	12	16	2	55	0.81	98.4	81.063	61.8929
2025	4	12	16	12	55	0.78	95	81.063	60.1245
2025	4	12	16	22	55	0.82	95.7	81.1286	62.9566
2025	4	12	16	32	55	0.84	96.5	81.1286	63.968
2025	4	12	16	42	55	0.8	93.3	81.1286	61.1868
2025	4	12	16	52	55	0.79	95.7	81.1286	60.6811
2025	4	12	17	2	55	0.82	95.9	81.1942	63.2629
2025	4	12	17	12	55	0.84	96.3	81.063	64.1666
2025	4	12	17	22	55	0.81	97	81.1286	61.6926
2025	4	12	17	32	55	0.84	96.2	81.1942	64.7814
2025	4	12	17	42	55	0.78	96.7	81.1942	59.9734
2025	4	12	17	52	55	0.8	96.9	81.1942	60.9857
2025	4	12	18	2	55	0.83	96.6	81.1942	63.2632
2025	4	12	18	12	55	0.8	95.4	81.2598	61.2905
2025	4	12	18	22	55	0.81	95.8	81.2598	62.5569
2025	4	12	18	32	55	0.84	96.5	81.2598	64.0765
2025	4	12	18	42	55	0.83	95.5	81.3255	63.6237
2025	4	12	18	52	55	0.82	95.3	81.3255	62.8633
2025	4	12	19	2	55	0.82	97.8	81.2598	62.8103
2025	4	12	19	12	55	0.78	96.8	81.2598	59.5179
2025	4	12	19	22	55	0.85	97.1	81.3255	64.8912
2025	4	12	19	32	55	0.82	95.3	81.3255	62.8634
2025	4	12	19	42	55	0.83	97.5	81.3255	63.3705
2025	4	12	19	52	55	0.85	96.9	81.3255	64.8914
2025	4	12	20	2	55	0.85	97.8	81.3255	65.1449
2025	4	12	20	12	55	0.78	96.5	81.3255	60.0754
2025	4	12	20	22	55	0.79	96.2	81.2598	60.5313
2025	4	12	20	32	55	0.77	97.8	81.2598	59.265
2025	4	12	20	42	55	0.8	94.7	81.2598	61.2912
2025	4	12	20	52	55	0.83	95.4	81.2598	64.0772
2025	4	12	21	2	55	0.85	96	81.2598	65.0904
2025	4	12	21	12	55	0.81	94.9	81.2598	62.3044
2025	4	12	21	22	55	0.82	97.1	81.2598	63.0643
2025	4	12	21	32	55	0.78	93.6	81.2598	60.0251
2025	4	12	21	42	55	0.84	97	81.2598	64.3307
2025	4	12	21	52	55	0.81	96.3	81.2598	62.0513
2025	4	12	22	2	55	0.83	95.2	81.2598	63.571
2025	4	12	22	12	55	0.79	96.7	81.2598	60.2785
2025	4	12	22	22	55	0.77	92.9	81.2598	59.0122
2025	4	12	22	32	55	0.79	93.8	81.2598	60.5319
2025	4	12	22	42	55	0.8	97.1	81.3255	61.0899
2025	4	12	22	52	55	0.83	94.6	81.3255	63.6248
2025	4	12	23	2	55	0.79	95.7	81.3255	60.583
2025	4	12	23	12	55	0.83	98.9	81.3255	63.1179
2025	4	12	23	22	55	0.82	97.4	81.3255	62.8644
2025	4	12	23	32	55	0.8	95	81.2598	61.2918
2025	4	12	23	42	55	0.83	96.1	81.2598	63.8246
2025	4	12	23	52	55	0.8	96.1	81.2598	61.2919

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	13	0	2	55	0.81	95.3	81.2598	62.305
2025	4	13	0	12	55	0.85	95.7	81.2598	65.5975
2025	4	13	0	22	55	0.84	95.6	81.2598	64.3312
2025	4	13	0	32	55	0.86	96.6	81.2598	65.5976
2025	4	13	0	42	55	0.78	98.3	81.2598	59.2658
2025	4	13	0	52	55	0.85	96.9	81.3255	64.8925
2025	4	13	1	2	55	0.82	97.8	81.3255	62.6111
2025	4	13	1	12	55	0.81	96.3	81.2598	62.0518
2025	4	13	1	22	55	0.79	95.2	81.3255	61.0902
2025	4	13	1	32	55	0.82	96.2	81.3255	62.8646
2025	4	13	1	42	55	0.81	97.4	81.3255	62.3577
2025	4	13	1	52	55	0.83	96.4	81.3255	63.3716
2025	4	13	2	2	55	0.81	96.3	81.2598	62.0518
2025	4	13	2	12	55	0.79	97.8	81.2598	60.7855
2025	4	13	2	22	55	0.82	94.1	81.2598	63.3182
2025	4	13	2	32	55	0.77	98.4	81.2598	58.506
2025	4	13	2	42	55	0.85	98.7	81.2598	64.5846
2025	4	13	2	52	55	0.77	97.5	81.2598	59.2658
2025	4	13	3	2	55	0.81	97.2	81.3255	61.8507
2025	4	13	3	12	55	0.82	95.5	81.2598	63.3182
2025	4	13	3	22	55	0.8	95.6	81.2598	61.7986
2025	4	13	3	32	55	0.79	94.8	81.2598	60.7855
2025	4	13	3	42	55	0.77	95.3	81.2598	59.5191
2025	4	13	3	52	55	0.77	95.6	81.2598	59.5191
2025	4	13	4	2	55	0.86	95.5	81.2598	66.1042
2025	4	13	4	12	55	0.78	93.4	81.2598	59.7724
2025	4	13	4	22	55	0.8	95.2	81.2598	61.5453
2025	4	13	4	32	55	0.83	96.1	81.3255	63.6251
2025	4	13	4	42	55	0.85	95.5	81.3255	65.3995
2025	4	13	4	52	55	0.76	94.4	81.3255	58.8088
2025	4	13	5	2	55	0.76	95.2	81.3255	58.5553
2025	4	13	5	12	55	0.79	98.9	81.3255	60.0763
2025	4	13	5	22	55	0.82	96.7	81.3255	62.6111
2025	4	13	5	32	55	0.81	95.6	81.3911	62.1565
2025	4	13	5	42	55	0.8	96.4	81.3911	61.1417
2025	4	13	5	52	55	0.77	97.1	81.3911	59.3658
2025	4	13	6	2	55	0.79	96.4	81.3911	60.888
2025	4	13	6	12	55	0.82	96.7	81.3911	62.6638
2025	4	13	6	22	55	0.81	94.7	81.3911	62.1564
2025	4	13	6	32	55	0.83	95	81.4567	63.7322
2025	4	13	6	42	55	0.8	93.8	81.3911	61.3953
2025	4	13	6	52	55	0.84	97.4	81.4567	64.7479
2025	4	13	7	2	55	0.84	97	81.4567	64.24
2025	4	13	7	12	55	0.78	97.5	81.3911	60.1268
2025	4	13	7	22	55	0.77	96.1	81.5223	59.2115
2025	4	13	7	32	55	0.78	95.1	81.4567	60.1774
2025	4	13	7	42	55	0.84	96.5	81.4567	64.4939
2025	4	13	7	52	55	0.77	93.9	81.4567	59.4156

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	13	8	2	55	0.76	95.7	81.3911	58.6045
2025	4	13	8	12	55	0.81	94.4	81.4567	62.7164
2025	4	13	8	22	55	0.77	94.6	81.4567	59.4155
2025	4	13	8	32	55	0.76	96.2	81.3911	58.3507
2025	4	13	8	42	55	0.77	96.8	81.4567	59.4155
2025	4	13	8	52	55	0.75	94.7	81.3911	58.0969
2025	4	13	9	2	55	0.78	95.5	81.4567	60.431
2025	4	13	9	12	55	0.81	96.3	81.4567	62.4623
2025	4	13	9	22	55	0.81	97	81.4567	62.2083
2025	4	13	9	32	55	0.83	97.3	81.4567	63.4779
2025	4	13	9	42	55	0.78	93.6	81.4567	60.177
2025	4	13	9	52	55	0.79	96	81.4567	60.4309
2025	4	13	10	2	55	0.83	96.6	81.4567	63.7317
2025	4	13	10	12	55	0.82	96.2	81.5223	63.0229
2025	4	13	10	22	55	0.79	95.7	81.4567	61.1925
2025	4	13	10	32	55	0.82	94.8	81.4567	63.2237
2025	4	13	10	42	55	0.8	94.2	81.4567	61.9541
2025	4	13	10	52	55	0.83	96.1	81.5223	64.2933
2025	4	13	11	2	55	0.78	96.6	81.4567	59.6688
2025	4	13	11	12	55	0.79	96.4	81.4567	60.9383
2025	4	13	11	22	55	0.81	96.3	81.4567	62.2078
2025	4	13	11	32	55	0.77	96.4	81.4567	59.1609
2025	4	13	11	42	55	0.79	95	81.4567	60.9382
2025	4	13	11	52	55	0.77	95.6	81.4567	59.6686
2025	4	13	12	2	55	0.76	97.2	81.5223	58.7023
2025	4	13	12	12	55	0.79	96	81.5223	60.7352
2025	4	13	12	22	55	0.81	95.3	81.5223	62.514
2025	4	13	12	32	55	0.83	97.1	81.5223	63.5305
2025	4	13	12	42	55	0.8	97.7	81.5223	61.7516
2025	4	13	12	52	55	0.78	94.8	81.5223	59.9728
2025	4	13	13	2	55	0.77	97.3	81.5223	59.4646
2025	4	13	13	12	55	0.79	94	81.5223	61.2434
2025	4	13	13	22	55	0.76	95.7	81.5223	58.4481
2025	4	13	13	32	55	0.83	96.4	81.5223	63.5305
2025	4	13	13	42	55	0.8	99	81.5223	60.9892
2025	4	13	13	52	55	0.78	93.6	81.5223	60.2269
2025	4	13	14	2	55	0.83	97.3	81.5223	63.5304
2025	4	13	14	12	55	0.8	96.4	81.5879	61.2949
2025	4	13	14	22	55	0.8	97.1	81.5879	61.5492
2025	4	13	14	32	55	0.79	95.2	81.5223	61.2434
2025	4	13	14	42	55	0.84	95	81.5879	64.6012
2025	4	13	14	52	55	0.78	96.7	81.5879	60.2775
2025	4	13	15	2	55	0.81	94.2	81.5879	62.8209
2025	4	13	15	12	55	0.8	96.6	81.5879	61.8035
2025	4	13	15	22	55	0.82	97.3	81.5879	63.3295
2025	4	13	15	32	55	0.85	94.4	81.5879	65.3642
2025	4	13	15	42	55	0.85	95.5	81.5879	65.8729
2025	4	13	15	52	55	0.82	96.4	81.5879	63.0752

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	13	16	2	55	0.82	95	81.5879	63.3296
2025	4	13	16	12	55	0.82	96.4	81.5879	63.0752
2025	4	13	16	22	55	0.81	97.2	81.5879	62.3122
2025	4	13	16	32	55	0.82	97.4	81.5879	62.8209
2025	4	13	16	42	55	0.85	94.7	81.5879	65.6186
2025	4	13	16	52	55	0.79	93.6	81.5879	61.2949
2025	4	13	17	2	55	0.84	97.8	81.5879	64.6013
2025	4	13	17	12	55	0.85	97.1	81.5879	65.6187
2025	4	13	17	22	55	0.84	96.1	81.5879	64.6014
2025	4	13	17	32	55	0.8	97.5	81.5879	61.5493
2025	4	13	17	42	55	0.8	96.1	81.5879	61.8037
2025	4	13	17	52	55	0.79	94.8	81.5879	61.0407
2025	4	13	18	2	55	0.8	95.4	81.5879	61.8038
2025	4	13	18	12	55	0.88	96.9	81.5879	67.6535
2025	4	13	18	22	55	0.79	96.4	81.5879	61.0408
2025	4	13	18	32	55	0.83	95.5	81.5879	63.8386
2025	4	13	18	42	55	0.84	97.4	81.5879	64.3473
2025	4	13	18	52	55	0.86	94.8	81.5879	66.382
2025	4	13	19	2	55	0.84	95.8	81.5879	64.6017
2025	4	13	19	12	55	0.84	94.1	81.5879	64.6018
2025	4	13	19	22	55	0.82	96.2	81.6535	63.6379
2025	4	13	19	32	55	0.8	97.5	81.6535	61.8561
2025	4	13	19	42	55	0.79	95.7	81.7192	60.889
2025	4	13	19	52	55	0.82	94.6	81.7848	63.7449
2025	4	13	20	2	55	0.82	98	81.7848	63.235
2025	4	13	20	12	55	0.82	97.6	81.7848	63.235
2025	4	13	20	22	55	0.81	97.5	81.7848	62.2151
2025	4	13	20	32	55	0.87	96.1	81.7848	67.0598
2025	4	13	20	42	55	0.85	96.6	81.7848	65.785
2025	4	13	20	52	55	0.85	96.4	81.7848	65.53
2025	4	13	21	2	55	0.79	96	81.7848	60.6854
2025	4	13	21	12	55	0.85	97.5	81.7848	65.5301
2025	4	13	21	22	55	0.84	94	81.7848	65.0202
2025	4	13	21	32	55	0.84	97.6	81.7848	65.0203
2025	4	13	21	42	55	0.83	94.1	81.7848	64.5103
2025	4	13	21	52	55	0.82	94.3	81.8504	63.7989
2025	4	13	22	2	55	0.82	95.3	81.7848	63.4905
2025	4	13	22	12	55	0.85	97.3	81.7848	65.7854
2025	4	13	22	22	55	0.85	96.9	81.7848	65.5304
2025	4	13	22	32	55	0.83	96.1	81.7848	64.2556
2025	4	13	22	42	55	0.81	96.3	81.7848	62.7257
2025	4	13	22	52	55	0.82	95.3	81.7848	63.7457
2025	4	13	23	2	55	0.86	98.8	81.7848	66.0406
2025	4	13	23	12	55	0.81	96.8	81.7848	62.2158
2025	4	13	23	22	55	0.79	95.7	81.7848	60.941
2025	4	13	23	32	55	0.86	97.9	81.7848	66.2956
2025	4	13	23	42	55	0.81	97.4	81.7848	62.4709
2025	4	13	23	52	55	0.83	96.1	81.7848	64.0008

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	14	0	2	55	0.81	96.5	81.7848	62.216
2025	4	14	0	12	55	0.85	96.7	81.7848	65.2758
2025	4	14	0	22	55	0.85	95.8	81.7848	65.5308
2025	4	14	0	32	55	0.81	96.1	81.7848	62.216
2025	4	14	0	42	55	0.82	97.5	81.7848	63.491
2025	4	14	0	52	55	0.79	95.7	81.8504	61.2474
2025	4	14	1	2	55	0.76	93.9	81.7848	59.1563
2025	4	14	1	12	55	0.78	95.1	81.7848	60.4312
2025	4	14	1	22	55	0.81	95.8	81.7848	62.7261
2025	4	14	1	32	55	0.8	97	81.8504	62.013
2025	4	14	1	42	55	0.77	96.6	81.7848	59.4113
2025	4	14	1	52	55	0.81	98.9	81.8504	62.2683
2025	4	14	2	2	55	0.84	97.9	81.8504	64.5651
2025	4	14	2	12	55	0.8	97.3	81.8504	61.7579
2025	4	14	2	22	55	0.82	96.2	81.8504	63.2891
2025	4	14	2	32	55	0.82	96.2	81.8504	63.0339
2025	4	14	2	42	55	0.82	96.9	81.8504	63.5443
2025	4	14	2	52	55	0.85	95.8	81.8504	65.5859
2025	4	14	3	2	55	0.82	95.5	81.8504	63.2891
2025	4	14	3	12	55	0.82	95.3	81.8504	63.2891
2025	4	14	3	22	55	0.84	95.1	81.8504	65.3307
2025	4	14	3	32	55	0.84	99	81.8504	64.5651
2025	4	14	3	42	55	0.84	97.9	81.8504	64.5651
2025	4	14	3	52	55	0.81	95.3	81.8504	62.7787
2025	4	14	4	2	55	0.84	97.2	81.8504	64.5651
2025	4	14	4	12	55	0.8	95.9	81.8504	62.0131
2025	4	14	4	22	55	0.82	98.3	81.8504	63.0339
2025	4	14	4	32	55	0.81	96.1	81.8504	62.5235
2025	4	14	4	42	55	0.8	95.2	81.8504	61.7579
2025	4	14	4	52	55	0.82	96.2	81.8504	63.0339
2025	4	14	5	2	55	0.82	96.7	81.8504	63.0339
2025	4	14	5	12	55	0.84	95.4	81.8504	65.0755
2025	4	14	5	22	55	0.82	96.4	81.8504	63.5443
2025	4	14	5	32	55	0.82	98.1	81.8504	63.0339
2025	4	14	5	42	55	0.83	93.6	81.8504	64.3099
2025	4	14	5	52	55	0.85	94.7	81.8504	65.5859
2025	4	14	6	2	55	0.82	97.8	81.8504	63.0339
2025	4	14	6	12	55	0.85	96.4	81.8504	65.5859
2025	4	14	6	22	55	0.82	94.4	81.8504	63.2891
2025	4	14	6	32	55	0.82	97.6	81.8504	63.2891
2025	4	14	6	42	55	0.81	95.6	81.8504	62.5235
2025	4	14	6	52	55	0.81	95.6	81.8504	62.5235
2025	4	14	7	2	55	0.84	98.3	81.8504	64.565
2025	4	14	7	12	55	0.82	95.7	81.8504	63.5442
2025	4	14	7	22	55	0.85	94.7	81.8504	65.5858
2025	4	14	7	32	55	0.81	96.1	81.916	62.3203
2025	4	14	7	42	55	0.8	95.4	81.916	62.3203
2025	4	14	7	52	55	0.82	96.9	81.8504	63.5441

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	14	8	2	55	0.83	96.1	81.916	64.6189
2025	4	14	8	12	55	0.83	96.6	81.916	64.3634
2025	4	14	8	22	55	0.82	95.5	81.916	63.8526
2025	4	14	8	32	55	0.81	96.3	81.916	62.5755
2025	4	14	8	42	55	0.81	97	81.916	62.5754
2025	4	14	8	52	55	0.84	99.6	81.916	64.6187
2025	4	14	9	2	55	0.83	94.5	81.916	64.6186
2025	4	14	9	12	55	0.8	97.7	81.916	62.0645
2025	4	14	9	22	55	0.84	96	81.916	65.1293
2025	4	14	9	32	55	0.81	93.7	81.916	62.8306
2025	4	14	9	42	55	0.85	96.4	81.916	65.64
2025	4	14	9	52	55	0.81	94.2	81.916	63.0859
2025	4	14	10	2	55	0.79	95.2	81.916	61.2981
2025	4	14	10	12	55	0.78	95.1	81.9816	60.3268
2025	4	14	10	22	55	0.82	97.4	81.9816	63.3943
2025	4	14	10	32	55	0.82	97.4	81.9816	63.1386
2025	4	14	10	42	55	0.8	97.3	81.9816	61.8604
2025	4	14	10	52	55	0.85	96.9	81.9816	65.4391
2025	4	14	11	2	55	0.83	96.4	81.9816	63.9053
2025	4	14	11	12	55	0.83	97.5	81.9816	64.1609
2025	4	14	11	22	55	0.84	95.8	81.9816	65.4389
2025	4	14	11	32	55	0.8	94.9	81.9816	62.3715
2025	4	14	11	42	55	0.78	96.5	81.9816	60.5821
2025	4	14	11	52	55	0.78	96.8	81.9816	60.3264
2025	4	14	12	2	55	0.81	95.3	81.9816	62.8826
2025	4	14	12	12	55	0.82	96.2	81.9816	63.6494
2025	4	14	12	22	55	0.8	95.4	81.916	62.0637
2025	4	14	12	32	55	0.8	94.5	82.0472	62.4234
2025	4	14	12	42	55	0.76	95.9	81.9816	59.0481
2025	4	14	12	52	55	0.76	95.2	82.0472	59.0975
2025	4	14	13	2	55	0.82	96.7	81.9816	63.3936
2025	4	14	13	12	55	0.78	95.5	82.0472	60.8883
2025	4	14	13	22	55	0.8	95.9	81.9816	61.8598
2025	4	14	13	32	55	0.85	96.2	81.9816	65.6941
2025	4	14	13	42	55	0.83	97.2	82.0472	64.4698
2025	4	14	13	52	55	0.8	94.3	81.9816	61.8597
2025	4	14	14	2	55	0.81	97	82.0472	62.6789
2025	4	14	14	12	55	0.83	97	82.0472	64.2139
2025	4	14	14	22	55	0.79	93.8	81.9816	61.604
2025	4	14	14	32	55	0.82	93.7	82.1129	63.4994
2025	4	14	14	42	55	0.82	95	82.1129	64.0114
2025	4	14	14	52	55	0.8	94	82.0472	62.423
2025	4	14	15	2	55	0.83	95.2	82.0472	64.2138
2025	4	14	15	12	55	0.85	95.1	82.0472	65.7488
2025	4	14	15	22	55	0.78	95.8	82.0472	60.3763
2025	4	14	15	32	55	0.82	96.2	82.0472	63.7022
2025	4	14	15	42	55	0.81	94.9	82.0472	62.6788
2025	4	14	15	52	55	0.81	98.4	82.0472	62.6788

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	14	16	2	55	0.81	95.3	82.0472	63.1905
2025	4	14	16	12	55	0.82	96.2	82.0472	63.7022
2025	4	14	16	22	55	0.84	95.2	82.0472	64.9814
2025	4	14	16	32	55	0.78	91.7	82.0472	61.1439
2025	4	14	16	42	55	0.81	94.4	82.0472	62.9348
2025	4	14	16	52	55	0.81	96.3	82.1129	62.9874
2025	4	14	17	2	55	0.83	96.4	82.1129	64.0116
2025	4	14	17	12	55	0.81	98.4	82.1129	62.2193
2025	4	14	17	22	55	0.83	94.3	82.1129	64.2677
2025	4	14	17	32	55	0.82	97.4	82.1129	63.2435
2025	4	14	17	42	55	0.81	97.7	82.1129	62.7315
2025	4	14	17	52	55	0.83	95.9	82.1129	64.2678
2025	4	14	18	2	55	0.85	96.4	82.1129	66.0602
2025	4	14	18	12	55	0.86	95.9	82.1129	66.5723
2025	4	14	18	22	55	0.81	97.9	82.1129	62.9876
2025	4	14	18	32	55	0.85	98.2	82.1129	65.5482
2025	4	14	18	42	55	0.83	96.8	82.1129	64.0119
2025	4	14	18	52	55	0.87	96.9	82.1129	67.5966
2025	4	14	19	2	55	0.79	97.4	82.1129	61.1955
2025	4	14	19	12	55	0.83	97.3	82.1129	64.2681
2025	4	14	19	22	55	0.85	97.6	82.1129	65.5484
2025	4	14	19	32	55	0.85	98	82.1129	65.8045
2025	4	14	19	42	55	0.83	97.3	82.1129	64.2682
2025	4	14	19	52	55	0.85	95.8	82.1129	65.8046
2025	4	14	20	2	55	0.84	97.2	82.1129	65.0365
2025	4	14	20	12	55	0.84	95.2	82.1129	65.2925
2025	4	14	20	22	55	0.87	97	82.1129	67.0849
2025	4	14	20	32	55	0.81	96	82.1129	63.2442
2025	4	14	20	42	55	0.81	98.6	82.1129	62.4761
2025	4	14	20	52	55	0.86	97.9	82.1129	66.3169
2025	4	14	21	2	55	0.83	97.5	82.1129	64.0125
2025	4	14	21	12	55	0.8	96.3	82.1129	62.2202
2025	4	14	21	22	55	0.86	97.2	82.1129	66.8291
2025	4	14	21	32	55	0.84	94	82.1129	65.2929
2025	4	14	21	42	55	0.83	97.5	82.1129	64.0126
2025	4	14	21	52	55	0.85	95.7	82.1129	66.3171
2025	4	14	22	2	55	0.84	95	82.1129	65.0369
2025	4	14	22	12	55	0.85	96.2	82.1129	66.0611
2025	4	14	22	22	55	0.83	96.1	82.1129	64.7809
2025	4	14	22	32	55	0.83	97.7	82.1129	64.5249
2025	4	14	22	42	55	0.83	93.8	82.1129	64.781
2025	4	14	22	52	55	0.85	96.4	82.1785	65.8601
2025	4	14	23	2	55	0.81	95.5	82.1785	63.2975
2025	4	14	23	12	55	0.85	96.2	82.1785	66.1165
2025	4	14	23	22	55	0.84	95.2	82.1785	65.0914
2025	4	14	23	32	55	0.82	95.3	82.2441	64.1199
2025	4	14	23	42	55	0.83	96.8	82.2441	64.3764
2025	4	14	23	52	55	0.87	97.4	82.2441	67.1977

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	15	0	2	55	0.84	97	82.2441	65.1459
2025	4	15	0	12	55	0.81	97.5	82.2441	62.5811
2025	4	15	0	22	55	0.86	95.5	82.3097	66.997
2025	4	15	0	32	55	0.85	95.3	82.3097	66.227
2025	4	15	0	42	55	0.83	95.9	82.3097	64.9435
2025	4	15	0	52	55	0.84	95.6	82.3097	65.7136
2025	4	15	1	2	55	0.86	95.9	82.3097	66.9971
2025	4	15	1	12	55	0.88	97.1	82.3753	68.3375
2025	4	15	1	22	55	0.85	97.7	82.3753	66.2822
2025	4	15	1	32	55	0.81	96.1	82.3753	62.6855
2025	4	15	1	42	55	0.84	93.8	82.3097	65.457
2025	4	15	1	52	55	0.79	96.2	82.3097	61.6066
2025	4	15	2	2	55	0.82	98	82.3753	63.9701
2025	4	15	2	12	55	0.81	94.9	82.3753	63.4563
2025	4	15	2	22	55	0.86	95.9	82.3097	66.7405
2025	4	15	2	32	55	0.83	95.9	82.3753	64.9977
2025	4	15	2	42	55	0.87	97.8	82.3753	67.8237
2025	4	15	2	52	55	0.83	94.8	82.3753	64.7408
2025	4	15	3	2	55	0.82	96.2	82.3753	63.7132
2025	4	15	3	12	55	0.81	95.6	82.3753	62.9425
2025	4	15	3	22	55	0.84	95.8	82.3753	65.5116
2025	4	15	3	32	55	0.82	94.6	82.3097	63.9169
2025	4	15	3	42	55	0.85	96.7	82.3753	66.0254
2025	4	15	3	52	55	0.83	96.8	82.3753	64.7408
2025	4	15	4	2	55	0.81	96.8	82.3097	62.8901
2025	4	15	4	12	55	0.83	93.2	82.3753	64.9978
2025	4	15	4	22	55	0.84	95.8	82.3753	65.7685
2025	4	15	4	32	55	0.86	96.8	82.3753	66.7961
2025	4	15	4	42	55	0.86	96.4	82.3753	66.7961
2025	4	15	4	52	55	0.84	98.3	82.3753	64.9978
2025	4	15	5	2	55	0.85	94.9	82.3753	66.2823
2025	4	15	5	12	55	0.82	94.8	82.3753	63.7132
2025	4	15	5	22	55	0.82	93.4	82.3753	64.4839
2025	4	15	5	32	55	0.84	97.8	82.3753	65.2547
2025	4	15	5	42	55	0.81	93.3	82.3753	62.9425
2025	4	15	5	52	55	0.82	95.3	82.3753	63.7132
2025	4	15	6	2	55	0.82	97.1	82.3753	63.7132
2025	4	15	6	12	55	0.85	97.1	82.3753	66.0254
2025	4	15	6	22	55	0.84	94.3	82.3753	65.5116
2025	4	15	6	32	55	0.81	95.8	82.3753	63.1994
2025	4	15	6	42	55	0.8	95.2	82.3753	62.6855
2025	4	15	6	52	55	0.81	94.6	82.3753	63.1993
2025	4	15	7	2	55	0.81	97.2	82.3753	62.9424
2025	4	15	7	12	55	0.82	95.5	82.3753	63.7131
2025	4	15	7	22	55	0.84	97	82.3753	65.2545
2025	4	15	7	32	55	0.82	95.3	82.3753	63.9699
2025	4	15	7	42	55	0.81	96	82.3753	63.4561
2025	4	15	7	52	55	0.82	96.2	82.3097	63.66

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	15	8	2	55	0.8	96.1	82.3097	62.1198
2025	4	15	8	12	55	0.81	95.3	82.3097	63.1465
2025	4	15	8	22	55	0.83	96.1	82.2441	64.6327
2025	4	15	8	32	55	0.83	97.5	82.2441	64.3762
2025	4	15	8	42	55	0.82	95.5	82.2441	63.8632
2025	4	15	8	52	55	0.83	96.1	82.2441	64.6326
2025	4	15	9	2	55	0.84	94.7	82.1785	65.3474
2025	4	15	9	12	55	0.8	96.4	82.1785	62.016
2025	4	15	9	22	55	0.82	94.6	82.1785	64.066
2025	4	15	9	32	55	0.81	94.4	82.1785	63.0409
2025	4	15	9	42	55	0.86	95.2	82.1785	67.1411
2025	4	15	9	52	55	0.81	98.4	82.1785	62.5283
2025	4	15	10	2	55	0.86	96.4	82.1129	66.3168
2025	4	15	10	12	55	0.79	95.5	82.1129	61.1958
2025	4	15	10	22	55	0.86	97.5	82.1129	66.3167
2025	4	15	10	32	55	0.82	96.6	82.1129	63.7562
2025	4	15	10	42	55	0.84	97.4	82.1129	64.7803
2025	4	15	10	52	55	0.83	96.6	82.1129	64.2682
2025	4	15	11	2	55	0.83	97	82.1129	64.2681
2025	4	15	11	12	55	0.79	94.3	82.1785	61.5028
2025	4	15	11	22	55	0.83	96.8	82.1785	64.578
2025	4	15	11	32	55	0.8	95.6	82.1785	62.5279
2025	4	15	11	42	55	0.85	98	82.1129	65.8043
2025	4	15	11	52	55	0.82	98.3	82.1129	63.2437
2025	4	15	12	2	55	0.8	95.4	82.1785	62.2715
2025	4	15	12	12	55	0.81	95.3	82.1129	62.9877
2025	4	15	12	22	55	0.83	94.5	82.1785	64.834
2025	4	15	12	32	55	0.8	97.1	82.1785	62.0151
2025	4	15	12	42	55	0.84	97.9	82.1785	64.8339
2025	4	15	12	52	55	0.82	95.7	82.1785	63.8089
2025	4	15	13	2	55	0.81	96.1	82.1129	62.7314
2025	4	15	13	12	55	0.87	95.2	82.1785	67.6528
2025	4	15	13	22	55	0.81	96.3	82.1129	62.9874
2025	4	15	13	32	55	0.79	95.5	82.2441	61.8102
2025	4	15	13	42	55	0.79	94.1	82.1785	61.5024
2025	4	15	13	52	55	0.78	95	82.1785	60.9898
2025	4	15	14	2	55	0.8	97.3	82.1785	61.7586
2025	4	15	14	12	55	0.82	97.6	82.1785	63.2961
2025	4	15	14	22	55	0.82	96.5	82.1785	63.2961
2025	4	15	14	32	55	0.83	93.4	82.1785	65.0899
2025	4	15	14	42	55	0.85	95.3	82.1785	66.115
2025	4	15	14	52	55	0.84	95.4	82.1785	65.0899
2025	4	15	15	2	55	0.85	96.4	82.1785	66.115
2025	4	15	15	12	55	0.82	96.2	82.1785	63.8086
2025	4	15	15	22	55	0.81	97.4	82.1785	62.7836
2025	4	15	15	32	55	0.81	94.7	82.1785	62.7836
2025	4	15	15	42	55	0.83	96.6	82.1785	64.3212
2025	4	15	15	52	55	0.83	96.6	82.1129	64.0115

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	15	16	2	55	0.8	95.2	82.1785	62.0149
2025	4	15	16	12	55	0.84	97.2	82.1129	65.2918
2025	4	15	16	22	55	0.84	98.1	82.1129	64.5236
2025	4	15	16	32	55	0.82	97.4	82.1785	63.2962
2025	4	15	16	42	55	0.86	97.9	82.1129	66.316
2025	4	15	16	52	55	0.81	95.1	82.1129	63.2435
2025	4	15	17	2	55	0.82	93.7	82.1129	63.7556
2025	4	15	17	12	55	0.86	95.7	82.1129	66.8282
2025	4	15	17	22	55	0.82	95.3	82.1129	63.7557
2025	4	15	17	32	55	0.86	93.7	82.1129	67.0843
2025	4	15	17	42	55	0.82	96.4	82.1129	63.7557
2025	4	15	17	52	55	0.81	95.8	82.1129	62.7316
2025	4	15	18	2	55	0.82	95	82.1129	63.7558
2025	4	15	18	12	55	0.87	97.8	82.1129	67.0845
2025	4	15	18	22	55	0.84	99	82.1129	64.524
2025	4	15	18	32	55	0.84	98.1	82.1129	65.0362
2025	4	15	18	42	55	0.85	98.8	82.1129	65.8044
2025	4	15	18	52	55	0.81	96	82.1129	62.9879
2025	4	15	19	2	55	0.84	98	82.1129	65.2924
2025	4	15	19	12	55	0.83	97.7	82.0472	64.4704
2025	4	15	19	22	55	0.82	98.3	82.0472	63.1913
2025	4	15	19	32	55	0.81	96	82.0472	63.1913
2025	4	15	19	42	55	0.83	96.1	82.0472	64.2147
2025	4	15	19	52	55	0.86	95.5	82.0472	66.7731
2025	4	15	20	2	55	0.81	94.4	82.0472	63.1914
2025	4	15	20	12	55	0.84	93.4	82.0472	65.2382
2025	4	15	20	22	55	0.82	96.4	82.0472	63.4474
2025	4	15	20	32	55	0.79	96.7	82.0472	61.4007
2025	4	15	20	42	55	0.87	100.9	81.9816	66.2063
2025	4	15	20	52	55	0.8	95.6	82.0472	62.4241
2025	4	15	21	2	55	0.84	98.1	82.0472	64.9825
2025	4	15	21	12	55	0.82	94.8	81.9816	63.6502
2025	4	15	21	22	55	0.83	97.2	81.9816	64.4171
2025	4	15	21	32	55	0.83	99.3	81.9816	63.9059
2025	4	15	21	42	55	0.85	96.9	81.9816	65.4397
2025	4	15	21	52	55	0.81	96.8	81.9816	62.6278
2025	4	15	22	2	55	0.84	95.8	81.9816	65.1841
2025	4	15	22	12	55	0.83	95.6	81.9816	64.6729
2025	4	15	22	22	55	0.83	96.1	81.9816	64.4173
2025	4	15	22	32	55	0.85	97.9	81.9816	65.9511
2025	4	15	22	42	55	0.8	95.4	81.9816	62.1167
2025	4	15	22	52	55	0.86	95.9	81.9816	66.4623
2025	4	15	23	2	55	0.85	95.8	81.9816	65.9511
2025	4	15	23	12	55	0.81	97.7	81.9816	62.3724
2025	4	15	23	22	55	0.84	98.5	81.9816	64.9287
2025	4	15	23	32	55	0.86	95.9	81.9816	66.4625
2025	4	15	23	42	55	0.86	96.6	81.9816	66.7181
2025	4	15	23	52	55	0.84	97.6	81.9816	65.1844

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	16	0	2	55	0.84	96.5	81.9816	65.1844
2025	4	16	0	12	55	0.84	96.7	81.9816	64.9288
2025	4	16	0	22	55	0.83	97.3	81.916	63.8529
2025	4	16	0	32	55	0.81	97.5	81.9816	62.3726
2025	4	16	0	42	55	0.84	97.2	81.916	64.6192
2025	4	16	0	52	55	0.77	94.4	81.916	60.0218
2025	4	16	1	2	55	0.84	96.2	81.916	65.3854
2025	4	16	1	12	55	0.82	95.9	81.916	63.853
2025	4	16	1	22	55	0.84	96.7	81.9816	64.9289
2025	4	16	1	32	55	0.87	97.2	81.9816	66.9739
2025	4	16	1	42	55	0.88	96	81.916	67.9396
2025	4	16	1	52	55	0.81	95.6	81.916	62.5759
2025	4	16	2	2	55	0.88	95.6	81.916	67.9396
2025	4	16	2	12	55	0.85	96.9	81.916	65.3854
2025	4	16	2	22	55	0.84	95.6	81.916	65.3854
2025	4	16	2	32	55	0.77	97.8	81.916	59.7664
2025	4	16	2	42	55	0.85	94.7	81.916	65.6408
2025	4	16	2	52	55	0.82	95.3	81.916	63.3422
2025	4	16	3	2	55	0.83	98	81.916	63.853
2025	4	16	3	12	55	0.81	97.4	81.916	62.8313
2025	4	16	3	22	55	0.83	95	81.916	64.6192
2025	4	16	3	32	55	0.8	95.2	81.916	62.3205
2025	4	16	3	42	55	0.86	94.2	81.916	66.4071
2025	4	16	3	52	55	0.84	95.2	81.916	64.8746
2025	4	16	4	2	55	0.83	97.2	81.916	64.3638
2025	4	16	4	12	55	0.82	98	81.916	63.5975
2025	4	16	4	22	55	0.83	94.6	81.916	64.1084
2025	4	16	4	32	55	0.82	95	81.916	63.5975
2025	4	16	4	42	55	0.82	95.5	81.916	63.3421
2025	4	16	4	52	55	0.82	95.5	81.916	63.8529
2025	4	16	5	2	55	0.87	95.8	81.916	67.6841
2025	4	16	5	12	55	0.82	95.1	81.916	63.3421
2025	4	16	5	22	55	0.86	95.7	81.916	66.6624
2025	4	16	5	32	55	0.81	96.3	81.916	62.5758
2025	4	16	5	42	55	0.86	94.4	81.916	66.6624
2025	4	16	5	52	55	0.89	98.5	81.916	68.7057
2025	4	16	6	2	55	0.84	95.6	81.916	65.3853
2025	4	16	6	12	55	0.83	96.4	81.916	64.1083
2025	4	16	6	22	55	0.85	94.9	81.916	65.6407
2025	4	16	6	32	55	0.82	95.3	81.916	63.5974
2025	4	16	6	42	55	0.82	96.9	81.916	63.342
2025	4	16	6	52	55	0.83	94.6	81.916	64.1082
2025	4	16	7	2	55	0.83	96.6	81.9816	63.9062
2025	4	16	7	12	55	0.85	96.9	81.916	65.6406
2025	4	16	7	22	55	0.82	96.6	81.916	63.5973
2025	4	16	7	32	55	0.83	95.2	81.9816	64.4174
2025	4	16	7	42	55	0.8	95.2	81.9816	62.1167
2025	4	16	7	52	55	0.83	97.5	81.9816	64.1617

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	16	8	2	55	0.83	96.4	81.9816	64.1616
2025	4	16	8	12	55	0.84	93.1	81.9816	65.6953
2025	4	16	8	22	55	0.81	95.5	81.9816	63.1391
2025	4	16	8	32	55	0.81	97	81.9816	62.8834
2025	4	16	8	42	55	0.79	93.6	81.9816	61.3496
2025	4	16	8	52	55	0.83	96.1	81.9816	64.1614
2025	4	16	9	2	55	0.82	97.4	81.9816	63.3945
2025	4	16	9	12	55	0.79	95.2	81.9816	61.605
2025	4	16	9	22	55	0.84	96.3	82.0472	65.2382
2025	4	16	9	32	55	0.8	95.6	82.0472	62.424
2025	4	16	9	42	55	0.79	94.8	82.0472	61.4006
2025	4	16	9	52	55	0.79	94.3	82.0472	61.4005
2025	4	16	10	2	55	0.82	97.4	82.0472	63.4471
2025	4	16	10	12	55	0.82	97.4	82.0472	63.1913
2025	4	16	10	22	55	0.83	97.7	82.0472	64.2145
2025	4	16	10	32	55	0.81	96.3	82.0472	62.4236
2025	4	16	10	42	55	0.81	96.3	82.1129	62.7318
2025	4	16	10	52	55	0.85	94.2	82.0472	66.0052
2025	4	16	11	2	55	0.85	96.5	82.1129	65.5482
2025	4	16	11	12	55	0.8	96.3	82.1129	62.2195
2025	4	16	11	22	55	0.79	95.2	82.1129	61.4513
2025	4	16	11	32	55	0.88	97.1	82.1129	67.8525
2025	4	16	11	42	55	0.87	98	82.1129	67.0843
2025	4	16	11	52	55	0.82	97.8	82.1129	63.7556
2025	4	16	12	2	55	0.85	97.7	82.1129	66.06
2025	4	16	12	12	55	0.85	97.5	82.1129	66.0599
2025	4	16	12	22	55	0.84	96.7	82.1129	65.0357
2025	4	16	12	32	55	0.83	96.8	82.1129	64.0115
2025	4	16	12	42	55	0.82	96.9	82.0472	63.7022
2025	4	16	12	52	55	0.82	97.3	82.1129	63.7553
2025	4	16	13	2	55	0.78	94.8	82.1129	60.6828
2025	4	16	13	12	55	0.83	97	82.1129	64.2674
2025	4	16	13	22	55	0.83	97.7	82.0472	63.9579
2025	4	16	13	32	55	0.83	96.6	82.1129	64.2673
2025	4	16	13	42	55	0.77	96.8	82.0472	59.8645
2025	4	16	13	52	55	0.81	96.5	82.0472	62.9345
2025	4	16	14	2	55	0.79	99.6	82.0472	60.632
2025	4	16	14	12	55	0.83	99.3	82.1785	64.0647
2025	4	16	14	22	55	0.83	94.1	82.1129	64.2673
2025	4	16	14	32	55	0.78	94.8	81.9816	60.5813
2025	4	16	14	42	55	0.83	94.8	82.0472	64.2136
2025	4	16	14	52	55	0.8	96.6	82.1129	62.2189
2025	4	16	15	2	55	0.83	96.1	82.0472	64.4694
2025	4	16	15	12	55	0.79	95.5	82.0472	61.1436
2025	4	16	15	22	55	0.81	97.2	82.0472	62.6786
2025	4	16	15	32	55	0.81	96.5	82.0472	62.4228
2025	4	16	15	42	55	0.81	96.7	82.0472	62.9345
2025	4	16	15	52	55	0.8	94.7	82.0472	61.9112

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	16	16	2	55	0.82	94.1	81.9816	63.9045
2025	4	16	16	12	55	0.85	96.2	81.9816	66.2051
2025	4	16	16	22	55	0.85	96	82.0472	66.0046
2025	4	16	16	32	55	0.8	93	81.9816	62.3708
2025	4	16	16	42	55	0.84	97.2	81.9816	64.9271
2025	4	16	16	52	55	0.83	97.2	81.916	64.362
2025	4	16	17	2	55	0.81	98.4	81.916	62.5742
2025	4	16	17	12	55	0.81	96.1	81.9816	62.6266
2025	4	16	17	22	55	0.83	96.6	81.9816	63.9047
2025	4	16	17	32	55	0.79	95.5	81.9816	61.3485
2025	4	16	17	42	55	0.83	96.3	81.916	64.3621
2025	4	16	17	52	55	0.8	93.8	81.9816	62.1155
2025	4	16	18	2	55	0.86	96.8	82.0472	66.2607
2025	4	16	18	12	55	0.87	95.9	82.0472	67.2841
2025	4	16	18	22	55	0.81	96.1	81.9816	62.6268
2025	4	16	18	32	55	0.85	96.7	82.0472	65.7492
2025	4	16	18	42	55	0.84	96.7	82.0472	65.2375
2025	4	16	18	52	55	0.85	94.7	81.9816	65.9499
2025	4	16	19	2	55	0.83	96.8	81.9816	64.4162
2025	4	16	19	12	55	0.87	95.9	81.9816	67.2281
2025	4	16	19	22	55	0.79	95.3	81.9816	61.0932
2025	4	16	19	32	55	0.82	96.9	81.9816	63.1382
2025	4	16	19	42	55	0.86	97	81.9816	66.2057
2025	4	16	19	52	55	0.85	97.3	81.9816	65.6945
2025	4	16	20	2	55	0.87	96.7	81.9816	66.9727
2025	4	16	20	12	55	0.84	94.7	81.9816	65.439
2025	4	16	20	22	55	0.81	96.3	81.9816	62.8828
2025	4	16	20	32	55	0.86	95.2	81.9816	66.9728
2025	4	16	20	42	55	0.86	95.5	81.9816	66.4616
2025	4	16	20	52	55	0.84	96	81.9816	65.1835
2025	4	16	21	2	55	0.84	96.2	81.916	65.3845
2025	4	16	21	12	55	0.8	95.4	81.9816	61.8605
2025	4	16	21	22	55	0.84	96.3	81.916	64.6183
2025	4	16	21	32	55	0.85	95.3	81.916	65.64
2025	4	16	21	42	55	0.81	95.8	81.916	62.5751
2025	4	16	21	52	55	0.83	96.6	81.916	64.363
2025	4	16	22	2	55	0.85	96	81.916	66.1509
2025	4	16	22	12	55	0.84	97.2	81.916	64.8739
2025	4	16	22	22	55	0.86	96.6	81.916	66.6618
2025	4	16	22	32	55	0.85	97.3	81.916	65.3848
2025	4	16	22	42	55	0.82	95.3	81.916	63.3415
2025	4	16	22	52	55	0.85	96.9	81.916	65.8956
2025	4	16	23	2	55	0.83	97	81.916	64.1078
2025	4	16	23	12	55	0.82	96.2	81.916	63.3416
2025	4	16	23	22	55	0.82	99	81.8504	63.0334
2025	4	16	23	32	55	0.84	97.6	81.916	65.1295
2025	4	16	23	42	55	0.83	97	81.8504	64.3094
2025	4	16	23	52	55	0.83	97.3	81.8504	63.799

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	17	0	2	55	0.81	100	81.8504	62.2679
2025	4	17	0	12	55	0.82	95.7	81.8504	63.5439
2025	4	17	0	22	55	0.84	96.1	81.8504	64.8199
2025	4	17	0	32	55	0.88	95.5	81.8504	68.3926
2025	4	17	0	42	55	0.82	97.5	81.8504	63.5439
2025	4	17	0	52	55	0.84	95.2	81.8504	65.0751
2025	4	17	1	2	55	0.85	97.8	81.8504	65.3303
2025	4	17	1	12	55	0.83	99.3	81.8504	64.0543
2025	4	17	1	22	55	0.82	96.9	81.8504	63.2887
2025	4	17	1	32	55	0.84	97	81.8504	64.8198
2025	4	17	1	42	55	0.85	95.8	81.8504	65.5854
2025	4	17	1	52	55	0.85	95.8	81.8504	65.8406
2025	4	17	2	2	55	0.89	96.6	81.8504	68.3926
2025	4	17	2	12	55	0.82	95.5	81.8504	63.5439
2025	4	17	2	22	55	0.86	96.8	81.8504	66.351
2025	4	17	2	32	55	0.88	95.4	81.8504	67.8822
2025	4	17	2	42	55	0.82	96.2	81.8504	63.5438
2025	4	17	2	52	55	0.87	97	81.8504	66.8614
2025	4	17	3	2	55	0.83	95.4	81.8504	64.3094
2025	4	17	3	12	55	0.84	98.3	81.8504	64.8198
2025	4	17	3	22	55	0.87	97.8	81.8504	67.1166
2025	4	17	3	32	55	0.84	99.2	81.8504	64.8198
2025	4	17	3	42	55	0.84	97	81.8504	64.8198
2025	4	17	3	52	55	0.85	96.2	81.8504	65.8406
2025	4	17	4	2	55	0.86	97	81.8504	66.0958
2025	4	17	4	12	55	0.81	96.3	81.8504	62.5231
2025	4	17	4	22	55	0.82	97.6	81.8504	63.2886
2025	4	17	4	32	55	0.81	96.5	81.8504	62.7783
2025	4	17	4	42	55	0.84	97.4	81.8504	64.8198
2025	4	17	4	52	55	0.81	97.7	81.8504	62.5231
2025	4	17	5	2	55	0.82	96.2	81.8504	63.799
2025	4	17	5	12	55	0.85	97.3	81.8504	65.3302
2025	4	17	5	22	55	0.84	96.5	81.8504	64.8198
2025	4	17	5	32	55	0.82	97.5	81.8504	63.5438
2025	4	17	5	42	55	0.85	96.2	81.8504	65.8406
2025	4	17	5	52	55	0.82	95.5	81.8504	63.5438
2025	4	17	6	2	55	0.78	94.3	81.8504	60.7367
2025	4	17	6	12	55	0.83	98.6	81.8504	64.0542
2025	4	17	6	22	55	0.87	97.8	81.8504	67.3717
2025	4	17	6	32	55	0.84	97	81.8504	64.5646
2025	4	17	6	42	55	0.82	97.4	81.8504	63.2886
2025	4	17	6	52	55	0.82	98.5	81.8504	63.0334
2025	4	17	7	2	55	0.85	98.9	81.8504	65.3301
2025	4	17	7	12	55	0.84	96.3	81.8504	64.8197
2025	4	17	7	22	55	0.79	95	81.8504	60.9918
2025	4	17	7	32	55	0.85	96.9	81.8504	65.3301
2025	4	17	7	42	55	0.83	96.8	81.8504	63.7988
2025	4	17	7	52	55	0.82	99.2	81.916	63.3414

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	17	8	2	55	0.85	95.3	81.916	65.6401
2025	4	17	8	12	55	0.82	96.7	81.916	63.086
2025	4	17	8	22	55	0.88	95.6	81.916	67.9387
2025	4	17	8	32	55	0.83	96.6	81.916	64.3629
2025	4	17	8	42	55	0.81	96.8	81.916	62.3196
2025	4	17	8	52	55	0.83	96.4	81.916	64.1074
2025	4	17	9	2	55	0.81	96	81.916	62.8303
2025	4	17	9	12	55	0.85	95.3	81.9816	66.2059
2025	4	17	9	22	55	0.84	97.8	81.9816	65.1834
2025	4	17	9	32	55	0.81	95.8	81.9816	62.6272
2025	4	17	9	42	55	0.83	96.4	81.9816	63.9052
2025	4	17	9	52	55	0.86	97	81.9816	66.717
2025	4	17	10	2	55	0.84	96.3	81.9816	65.1832
2025	4	17	10	12	55	0.85	97.3	81.9816	65.6944
2025	4	17	10	22	55	0.83	96.1	81.9816	64.4163
2025	4	17	10	32	55	0.85	97.6	81.9816	65.4387
2025	4	17	10	42	55	0.82	96.2	81.9816	63.3937
2025	4	17	10	52	55	0.81	96.3	81.9816	62.8824
2025	4	17	11	2	55	0.84	97	82.0472	64.9816
2025	4	17	11	12	55	0.81	95.6	82.0472	62.9348
2025	4	17	11	22	55	0.78	96.5	82.0472	60.6323
2025	4	17	11	32	55	0.85	95.6	82.0472	65.7489
2025	4	17	11	42	55	0.81	94.7	82.0472	62.6789
2025	4	17	11	52	55	0.84	94.3	82.0472	64.9813
2025	4	17	12	2	55	0.82	94.2	82.0472	63.4463
2025	4	17	12	12	55	0.83	95.9	82.0472	64.7254
2025	4	17	12	22	55	0.83	95.4	82.0472	64.7253
2025	4	17	12	32	55	0.82	96	82.0472	63.4461
2025	4	17	12	42	55	0.83	95.7	82.0472	64.4694
2025	4	17	12	52	55	0.83	96.6	81.9816	64.1599
2025	4	17	13	2	55	0.84	93.1	81.9816	65.6936
2025	4	17	13	12	55	0.82	96.2	81.9816	63.1375
2025	4	17	13	22	55	0.82	96.4	81.9816	63.6488
2025	4	17	13	32	55	0.79	96.2	81.9816	60.837
2025	4	17	13	42	55	0.83	96.4	81.9816	64.1601
2025	4	17	13	52	55	0.86	97.9	81.9816	66.205
2025	4	17	14	2	55	0.82	97.8	81.9816	63.3933
2025	4	17	14	12	55	0.79	95.5	81.9816	61.604
2025	4	17	14	22	55	0.8	94.7	81.9816	61.8596
2025	4	17	14	32	55	0.84	96.5	81.9816	64.6714
2025	4	17	14	42	55	0.8	96.1	81.8504	62.0112
2025	4	17	14	52	55	0.84	96.5	81.916	64.6172
2025	4	17	15	2	55	0.83	97	81.916	64.1064
2025	4	17	15	12	55	0.78	96.8	81.916	60.2753
2025	4	17	15	22	55	0.79	95.7	81.916	61.2969
2025	4	17	15	32	55	0.81	96	82.0472	62.9345
2025	4	17	15	42	55	0.82	95.5	81.916	63.8509
2025	4	17	15	52	55	0.82	94.3	81.916	63.8509

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	17	16	2	55	0.8	93.1	81.8504	61.756
2025	4	17	16	12	55	0.85	95.1	81.916	66.1496
2025	4	17	16	22	55	0.84	95.2	81.9816	65.1825
2025	4	17	16	32	55	0.83	96.8	81.8504	64.0528
2025	4	17	16	42	55	0.81	96	81.8504	62.7769
2025	4	17	16	52	55	0.82	94.8	81.916	63.3403
2025	4	17	17	2	55	0.83	95.2	81.8504	64.3081
2025	4	17	17	12	55	0.79	96.4	81.8504	61.2458
2025	4	17	17	22	55	0.79	95.5	81.916	61.2972
2025	4	17	17	32	55	0.81	95.3	81.8504	62.777
2025	4	17	17	42	55	0.83	94.3	81.8504	64.053
2025	4	17	17	52	55	0.85	94.7	81.916	65.8946
2025	4	17	18	2	55	0.81	96.1	81.8504	62.522
2025	4	17	18	12	55	0.83	95.4	81.916	64.6176
2025	4	17	18	22	55	0.82	94.8	81.916	63.596
2025	4	17	18	32	55	0.85	96.6	81.916	65.8947
2025	4	17	18	42	55	0.84	97	81.916	64.8732
2025	4	17	18	52	55	0.83	96.4	81.916	63.8516
2025	4	17	19	2	55	0.81	96.7	81.8504	62.7774
2025	4	17	19	12	55	0.85	94	81.916	65.8949
2025	4	17	19	22	55	0.83	96.6	81.916	64.1071
2025	4	17	19	32	55	0.82	96.2	81.916	63.8518
2025	4	17	19	42	55	0.8	95.4	81.916	62.064
2025	4	17	19	52	55	0.88	97.9	81.8504	67.6263
2025	4	17	20	2	55	0.82	94.4	81.8504	63.5433
2025	4	17	20	12	55	0.83	96.8	81.8504	64.0537
2025	4	17	20	22	55	0.85	97.3	81.8504	65.8401
2025	4	17	20	32	55	0.83	97.2	81.8504	64.309
2025	4	17	20	42	55	0.83	95.2	81.8504	64.0539
2025	4	17	20	52	55	0.89	97.4	81.8504	68.6474
2025	4	17	21	2	55	0.87	98.5	81.8504	66.8611
2025	4	17	21	12	55	0.86	97.9	81.7848	66.0402
2025	4	17	21	22	55	0.83	96.4	81.8504	63.7988
2025	4	17	21	32	55	0.84	96.1	81.7848	64.7654
2025	4	17	21	42	55	0.86	94.8	81.7848	66.2953
2025	4	17	21	52	55	0.84	92.9	81.7848	65.5304
2025	4	17	22	2	55	0.82	99.7	81.7848	62.4707
2025	4	17	22	12	55	0.84	95.2	81.7848	64.7655
2025	4	17	22	22	55	0.78	95.6	81.7192	60.1254
2025	4	17	22	32	55	0.84	96.1	81.7192	64.7113
2025	4	17	22	42	55	0.82	95.8	81.7192	63.1827
2025	4	17	22	52	55	0.85	96.9	81.7848	65.2756
2025	4	17	23	2	55	0.83	97.1	81.7192	63.6923
2025	4	17	23	12	55	0.82	97.3	81.7192	63.4376
2025	4	17	23	22	55	0.81	96.8	81.7192	62.1638
2025	4	17	23	32	55	0.83	95.6	81.7192	64.4567
2025	4	17	23	42	55	0.84	96.5	81.7192	64.9662
2025	4	17	23	52	55	0.79	96.7	81.7192	60.6352

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	18	0	2	55	0.81	95.3	81.7192	62.6734
2025	4	18	0	12	55	0.87	96.1	81.7192	67.2592
2025	4	18	0	22	55	0.82	96.9	81.7192	63.1829
2025	4	18	0	32	55	0.82	96.4	81.7192	63.1829
2025	4	18	0	42	55	0.82	96.4	81.7192	63.4377
2025	4	18	0	52	55	0.86	97	81.7192	66.2402
2025	4	18	1	2	55	0.82	95	81.7192	63.4378
2025	4	18	1	12	55	0.8	96.8	81.7192	61.6544
2025	4	18	1	22	55	0.84	96.3	81.6535	64.4028
2025	4	18	1	32	55	0.82	96.4	81.6535	63.1301
2025	4	18	1	42	55	0.78	97.5	81.6535	60.3299
2025	4	18	1	52	55	0.85	94.7	81.6535	65.4211
2025	4	18	2	2	55	0.79	95.2	81.6535	61.3482
2025	4	18	2	12	55	0.83	96.1	81.6535	64.4029
2025	4	18	2	22	55	0.85	96.2	81.6535	65.4211
2025	4	18	2	32	55	0.84	97.8	81.6535	64.6575
2025	4	18	2	42	55	0.84	96.7	81.6535	64.6575
2025	4	18	2	52	55	0.89	97.4	81.6535	68.4759
2025	4	18	3	2	55	0.8	95.4	81.6535	62.1119
2025	4	18	3	12	55	0.81	94.9	81.6535	62.3665
2025	4	18	3	22	55	0.82	97.4	81.6535	63.1302
2025	4	18	3	32	55	0.83	97.1	81.6535	63.6393
2025	4	18	3	42	55	0.83	95.9	81.6535	64.403
2025	4	18	3	52	55	0.86	94.6	81.6535	66.1849
2025	4	18	4	2	55	0.86	97	81.6535	66.4395
2025	4	18	4	12	55	0.79	93.6	81.6535	60.8392
2025	4	18	4	22	55	0.82	97.5	81.6535	63.3848
2025	4	18	4	32	55	0.84	95.6	81.6535	64.6576
2025	4	18	4	42	55	0.83	95.9	81.6535	64.1485
2025	4	18	4	52	55	0.82	95.3	81.6535	63.3848
2025	4	18	5	2	55	0.83	97.1	81.6535	63.6394
2025	4	18	5	12	55	0.8	98.2	81.6535	61.6029
2025	4	18	5	22	55	0.85	97.3	81.6535	65.1667
2025	4	18	5	32	55	0.87	96.5	81.6535	67.4578
2025	4	18	5	42	55	0.82	96.7	81.6535	63.1303
2025	4	18	5	52	55	0.84	97.9	81.6535	64.4031
2025	4	18	6	2	55	0.85	96.5	81.6535	65.1668
2025	4	18	6	12	55	0.8	97.3	81.6535	61.603
2025	4	18	6	22	55	0.83	98.4	81.6535	63.6394
2025	4	18	6	32	55	0.86	95.7	81.6535	66.6941
2025	4	18	6	42	55	0.81	97.4	81.5879	62.3143
2025	4	18	6	52	55	0.82	96.2	81.6535	63.6394
2025	4	18	7	2	55	0.8	95.4	81.5879	61.8056
2025	4	18	7	12	55	0.82	98.7	81.5879	62.8229
2025	4	18	7	22	55	0.8	96.1	81.5879	61.8055
2025	4	18	7	32	55	0.81	99.1	81.5223	61.7536
2025	4	18	7	42	55	0.84	94.5	81.5879	65.112
2025	4	18	7	52	55	0.81	96.3	81.5223	62.0076

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	18	8	2	55	0.79	95.7	81.5879	61.0424
2025	4	18	8	12	55	0.81	97.6	81.5223	62.5159
2025	4	18	8	22	55	0.83	97.1	81.5223	63.5324
2025	4	18	8	32	55	0.81	99.5	81.5223	62.0076
2025	4	18	8	42	55	0.79	96.7	81.5223	60.7369
2025	4	18	8	52	55	0.81	97.4	81.5223	62.2616
2025	4	18	9	2	55	0.8	97	81.5223	61.7533
2025	4	18	9	12	55	0.82	98.3	81.5223	62.7698
2025	4	18	9	22	55	0.79	97.4	81.5223	60.7368
2025	4	18	9	32	55	0.79	95.5	81.5223	60.7367
2025	4	18	9	42	55	0.81	96.3	81.5223	62.5156
2025	4	18	9	52	55	0.81	94.9	81.4567	62.7169
2025	4	18	10	2	55	0.81	96.1	81.4567	62.209
2025	4	18	10	12	55	0.78	95.6	81.4567	59.9238
2025	4	18	10	22	55	0.81	94.9	81.4567	62.7168
2025	4	18	10	32	55	0.83	96.4	81.4567	63.4785
2025	4	18	10	42	55	0.79	96.4	81.4567	60.9393
2025	4	18	10	52	55	0.84	96.3	81.4567	64.4941
2025	4	18	11	2	55	0.78	97	81.3911	60.1268
2025	4	18	11	12	55	0.82	95	81.4567	63.4783
2025	4	18	11	22	55	0.81	96.3	81.3911	62.4101
2025	4	18	11	32	55	0.79	93.3	81.4567	60.9391
2025	4	18	11	42	55	0.81	100.8	81.4567	61.4469
2025	4	18	11	52	55	0.84	96.2	81.4567	65.0017
2025	4	18	12	2	55	0.81	96.8	81.4567	61.9547
2025	4	18	12	12	55	0.85	97.7	81.4567	65.5094
2025	4	18	12	22	55	0.81	96.3	81.4567	61.9546
2025	4	18	12	32	55	0.8	96.3	81.3911	61.6488
2025	4	18	12	42	55	0.81	97.9	81.3911	62.4099
2025	4	18	12	52	55	0.85	96.9	81.4567	65.2554
2025	4	18	13	2	55	0.79	95.9	81.4567	60.9389
2025	4	18	13	12	55	0.85	94.9	81.4567	65.7632
2025	4	18	13	22	55	0.79	96.4	81.4567	60.9389
2025	4	18	13	32	55	0.8	98	81.4567	61.1928
2025	4	18	13	42	55	0.82	95.8	81.5223	63.0232
2025	4	18	13	52	55	0.79	95.9	81.3911	60.8876
2025	4	18	14	2	55	0.79	97.6	81.4567	60.9389
2025	4	18	14	12	55	0.81	95.3	81.4567	62.4623
2025	4	18	14	22	55	0.84	95.8	81.5223	65.0562
2025	4	18	14	32	55	0.83	97.9	81.4567	63.7319
2025	4	18	14	42	55	0.85	97.5	81.4567	65.2554
2025	4	18	14	52	55	0.8	95.7	81.5223	61.4984
2025	4	18	15	2	55	0.78	96	81.4567	60.1772
2025	4	18	15	12	55	0.81	95.4	81.4567	62.2085
2025	4	18	15	22	55	0.82	96.6	81.4567	63.2241
2025	4	18	15	32	55	0.79	95.5	81.4567	60.685
2025	4	18	15	42	55	0.82	96.7	81.4567	62.7164
2025	4	18	15	52	55	0.77	96.6	81.4567	58.9077

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	18	16	2	55	0.8	95.7	81.5223	61.4985
2025	4	18	16	12	55	0.8	96.4	81.4567	61.1929
2025	4	18	16	22	55	0.81	97.6	81.4567	62.4625
2025	4	18	16	32	55	0.86	96.8	81.4567	66.0174
2025	4	18	16	42	55	0.81	94.2	81.5223	62.5152
2025	4	18	16	52	55	0.82	96.2	81.4567	62.7166
2025	4	18	17	2	55	0.79	94.8	81.4567	60.9392
2025	4	18	17	12	55	0.88	95.1	81.4567	67.7949
2025	4	18	17	22	55	0.81	96.8	81.4567	61.9549
2025	4	18	17	32	55	0.86	96.6	81.4567	65.7637
2025	4	18	17	42	55	0.8	95.4	81.4567	61.7011
2025	4	18	17	52	55	0.81	98.4	81.3911	61.9029
2025	4	18	18	2	55	0.81	96.5	81.4567	62.463
2025	4	18	18	12	55	0.81	96.8	81.4567	62.2091
2025	4	18	18	22	55	0.81	95.3	81.4567	62.4631
2025	4	18	18	32	55	0.82	94.6	81.3911	63.1716
2025	4	18	18	42	55	0.82	97.1	81.3911	63.1717
2025	4	18	18	52	55	0.79	95.7	81.4567	60.6858
2025	4	18	19	2	55	0.8	95	81.3911	61.3959
2025	4	18	19	12	55	0.83	97	81.3911	63.933
2025	4	18	19	22	55	0.78	95.5	81.4567	60.432
2025	4	18	19	32	55	0.83	95	81.3911	63.9331
2025	4	18	19	42	55	0.82	96.5	81.3911	62.6646
2025	4	18	19	52	55	0.8	96.4	81.3911	61.3962
2025	4	18	20	2	55	0.82	95.1	81.3911	62.9184
2025	4	18	20	12	55	0.81	94	81.3911	62.1574
2025	4	18	20	22	55	0.8	95.6	81.3255	61.5981
2025	4	18	20	32	55	0.81	96.5	81.3911	61.9038
2025	4	18	20	42	55	0.81	96.5	81.3911	62.4112
2025	4	18	20	52	55	0.82	95	81.3911	63.1724
2025	4	18	21	2	55	0.79	93.8	81.3911	61.1428
2025	4	18	21	12	55	0.82	98	81.3911	63.1725
2025	4	18	21	22	55	0.79	95.3	81.3911	60.6355
2025	4	18	21	32	55	0.83	95.7	81.3911	63.9337
2025	4	18	21	42	55	0.78	96	81.3911	59.8745
2025	4	18	21	52	55	0.79	97.1	81.3911	60.8894
2025	4	18	22	2	55	0.82	99	81.3911	62.4116
2025	4	18	22	12	55	0.8	94.7	81.4567	61.4486
2025	4	18	22	22	55	0.82	96	81.4567	63.226
2025	4	18	22	32	55	0.86	97	81.4567	66.2731
2025	4	18	22	42	55	0.85	98.4	81.3911	65.2026
2025	4	18	22	52	55	0.78	97.5	81.3911	59.8747
2025	4	18	23	2	55	0.84	97.2	81.3911	64.1878
2025	4	18	23	12	55	0.86	94.6	81.3911	65.9638
2025	4	18	23	22	55	0.82	96.7	81.3911	62.9193
2025	4	18	23	32	55	0.81	99.1	81.3911	61.6508
2025	4	18	23	42	55	0.82	96.2	81.3911	62.9194
2025	4	18	23	52	55	0.81	98.1	81.3911	62.1583

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	19	0	2	55	0.8	97.6	81.3911	61.1435
2025	4	19	0	12	55	0.78	96.8	81.3911	59.6213
2025	4	19	0	22	55	0.87	97.2	81.3911	66.7251
2025	4	19	0	32	55	0.82	95.3	81.3911	62.9195
2025	4	19	0	42	55	0.85	97.1	81.3911	65.2029
2025	4	19	0	52	55	0.8	96.9	81.3911	61.1436
2025	4	19	1	2	55	0.86	97.7	81.3911	65.964
2025	4	19	1	12	55	0.78	94.6	81.3911	60.3825
2025	4	19	1	22	55	0.8	97.3	81.3911	61.651
2025	4	19	1	32	55	0.83	96.4	81.3911	63.427
2025	4	19	1	42	55	0.83	96.6	81.3911	63.6807
2025	4	19	1	52	55	0.85	96.5	81.3911	64.9493
2025	4	19	2	2	55	0.81	96	81.3911	62.6659
2025	4	19	2	12	55	0.84	96.7	81.3911	64.4418
2025	4	19	2	22	55	0.83	96.8	81.3911	63.427
2025	4	19	2	32	55	0.82	95.7	81.3911	63.427
2025	4	19	2	42	55	0.85	94.7	81.3911	65.4567
2025	4	19	2	52	55	0.85	95.1	81.3911	65.4567
2025	4	19	3	2	55	0.85	97.3	81.3911	65.4567
2025	4	19	3	12	55	0.82	97.8	81.3255	62.6131
2025	4	19	3	22	55	0.83	98	81.3255	63.3736
2025	4	19	3	32	55	0.83	95.9	81.3255	63.8806
2025	4	19	3	42	55	0.8	96.2	81.3255	61.0921
2025	4	19	3	52	55	0.82	96	81.3255	62.8666
2025	4	19	4	2	55	0.83	98.9	81.3255	63.1201
2025	4	19	4	12	55	0.82	98.5	81.3255	62.6131
2025	4	19	4	22	55	0.85	96.7	81.3255	65.1481
2025	4	19	4	32	55	0.83	98.2	81.3255	63.6271
2025	4	19	4	42	55	0.8	96.3	81.3255	61.5991
2025	4	19	4	52	55	0.86	96.6	81.3255	65.9086
2025	4	19	5	2	55	0.86	96.4	81.3255	65.6551
2025	4	19	5	12	55	0.83	93.8	81.3255	64.1341
2025	4	19	5	22	55	0.85	96.7	81.3255	64.8946
2025	4	19	5	32	55	0.82	96	81.3255	62.8666
2025	4	19	5	42	55	0.82	95.3	81.3255	62.8667
2025	4	19	5	52	55	0.84	96.7	81.3255	64.6411
2025	4	19	6	2	55	0.82	96.9	81.3255	62.8667
2025	4	19	6	12	55	0.86	96.6	81.3255	65.6551
2025	4	19	6	22	55	0.81	96.1	81.3255	61.8527
2025	4	19	6	32	55	0.82	96.7	81.3255	62.6132
2025	4	19	6	42	55	0.77	98.1	81.3255	59.0642
2025	4	19	6	52	55	0.86	98.1	81.3911	65.9641
2025	4	19	7	2	55	0.85	97.5	81.3255	65.1481
2025	4	19	7	12	55	0.82	96.7	81.3911	62.6659
2025	4	19	7	22	55	0.82	96	81.3911	63.1733
2025	4	19	7	32	55	0.85	93.3	81.3911	65.4566
2025	4	19	7	42	55	0.81	93.7	81.3911	62.4121
2025	4	19	7	52	55	0.82	96.2	81.3911	62.9195

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	19	8	2	55	0.83	96.3	81.3911	63.9343
2025	4	19	8	12	55	0.8	97.1	81.3911	61.3972
2025	4	19	8	22	55	0.83	95	81.3911	63.6805
2025	4	19	8	32	55	0.84	97.8	81.3911	64.4416
2025	4	19	8	42	55	0.84	95.8	81.3911	64.4416
2025	4	19	8	52	55	0.81	94.6	81.3911	62.6656
2025	4	19	9	2	55	0.8	95.2	81.3911	61.9044
2025	4	19	9	12	55	0.87	97.2	81.4567	66.781
2025	4	19	9	22	55	0.78	97.5	81.3911	60.1284
2025	4	19	9	32	55	0.86	96.4	81.4567	65.7652
2025	4	19	9	42	55	0.82	98	81.4567	63.226
2025	4	19	9	52	55	0.84	97.4	81.4567	64.7495
2025	4	19	10	2	55	0.86	96.6	81.4567	66.019
2025	4	19	10	12	55	0.84	97.4	81.4567	64.4955
2025	4	19	10	22	55	0.82	99.2	81.4567	62.718
2025	4	19	10	32	55	0.84	96.3	81.4567	64.4954
2025	4	19	10	42	55	0.87	99.3	81.4567	66.7806
2025	4	19	10	52	55	0.81	98.8	81.4567	62.21
2025	4	19	11	2	55	0.81	98.1	81.4567	62.21
2025	4	19	11	12	55	0.81	94.2	81.4567	62.7177
2025	4	19	11	22	55	0.83	98.9	81.4567	63.4795
2025	4	19	11	32	55	0.81	97.7	81.5223	62.008
2025	4	19	11	42	55	0.83	97.1	81.5223	63.5328
2025	4	19	11	52	55	0.84	98.8	81.5223	64.2952
2025	4	19	12	2	55	0.81	95.3	81.5223	62.5162
2025	4	19	12	12	55	0.82	98.1	81.5223	62.5161
2025	4	19	12	22	55	0.82	98.3	81.5223	62.5161
2025	4	19	12	32	55	0.83	95.2	81.5223	63.7867
2025	4	19	12	42	55	0.82	96.2	81.5223	63.0243
2025	4	19	12	52	55	0.84	97.4	81.5223	64.549
2025	4	19	13	2	55	0.83	95	81.4567	63.9869
2025	4	19	13	12	55	0.81	96.5	81.3911	61.9034
2025	4	19	13	22	55	0.84	97.8	81.3911	64.4404
2025	4	19	13	32	55	0.83	95	81.4567	63.7329
2025	4	19	13	42	55	0.83	94.3	81.4567	64.2407
2025	4	19	13	52	55	0.82	94.6	81.4567	63.225
2025	4	19	14	2	55	0.82	97.4	81.4567	62.7172
2025	4	19	14	12	55	0.8	97.3	81.4567	61.4476
2025	4	19	14	22	55	0.81	96	81.4567	62.7171
2025	4	19	14	32	55	0.84	96.8	81.3911	64.1866
2025	4	19	14	42	55	0.79	96.9	81.4567	60.9397
2025	4	19	14	52	55	0.81	96.5	81.4567	61.9554
2025	4	19	15	2	55	0.82	96.4	81.4567	62.971
2025	4	19	15	12	55	0.83	94.3	81.4567	64.2406
2025	4	19	15	22	55	0.78	95.3	81.4567	60.4319
2025	4	19	15	32	55	0.8	94.2	81.4567	61.7015
2025	4	19	15	42	55	0.82	96.2	81.4567	62.9711
2025	4	19	15	52	55	0.8	98	81.4567	61.4476

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	19	16	2	55	0.81	96.5	81.4567	62.4632
2025	4	19	16	12	55	0.82	98	81.4567	62.9711
2025	4	19	16	22	55	0.82	94.2	81.4567	62.9711
2025	4	19	16	32	55	0.8	98	81.4567	61.4476
2025	4	19	16	42	55	0.82	95.3	81.4567	63.2251
2025	4	19	16	52	55	0.83	94.8	81.4567	63.9869
2025	4	19	17	2	55	0.79	95.9	81.5223	61.2453
2025	4	19	17	12	55	0.83	96.1	81.4567	63.9869
2025	4	19	17	22	55	0.82	97.4	81.5223	62.7702
2025	4	19	17	32	55	0.84	95.4	81.5879	65.1121
2025	4	19	17	42	55	0.83	94.1	81.5223	64.0409
2025	4	19	17	52	55	0.81	99.1	81.5223	61.7537
2025	4	19	18	2	55	0.83	97.7	81.5879	63.5861
2025	4	19	18	12	55	0.85	97.3	81.5879	65.3666
2025	4	19	18	22	55	0.78	93.8	81.5879	60.5341
2025	4	19	18	32	55	0.83	97	81.5879	63.8406
2025	4	19	18	42	55	0.84	95.2	81.5879	64.6037
2025	4	19	18	52	55	0.8	95.4	81.5223	62.0081
2025	4	19	19	2	55	0.84	95.8	81.5223	65.0577
2025	4	19	19	12	55	0.84	96.7	81.5223	64.5495
2025	4	19	19	22	55	0.81	95.1	81.5223	62.5165
2025	4	19	19	32	55	0.83	95	81.5879	63.8409
2025	4	19	19	42	55	0.82	96	81.5879	63.0779
2025	4	19	19	52	55	0.84	98.8	81.5879	64.3497
2025	4	19	20	2	55	0.81	99.3	81.5879	62.0606
2025	4	19	20	12	55	0.81	97.9	81.5879	62.315
2025	4	19	20	22	55	0.86	96.8	81.5879	66.1302
2025	4	19	20	32	55	0.85	96.9	81.5879	65.6216
2025	4	19	20	42	55	0.83	92.9	81.5879	64.3499
2025	4	19	20	52	55	0.84	97.7	81.5879	64.3499
2025	4	19	21	2	55	0.84	96.5	81.5879	64.6043
2025	4	19	21	12	55	0.83	95.2	81.5879	64.35
2025	4	19	21	22	55	0.85	95.6	81.5879	65.3674
2025	4	19	21	32	55	0.83	97	81.5879	64.0957
2025	4	19	21	42	55	0.83	95.9	81.5223	64.296
2025	4	19	21	52	55	0.87	97.8	81.5223	66.8374
2025	4	19	22	2	55	0.83	96.6	81.5223	64.042
2025	4	19	22	12	55	0.88	97.7	81.5223	67.5999
2025	4	19	22	22	55	0.8	95.9	81.5223	61.5007
2025	4	19	22	32	55	0.85	97.3	81.5223	65.0586
2025	4	19	22	42	55	0.87	97.4	81.5223	66.8376
2025	4	19	22	52	55	0.81	95.1	81.5223	62.2632
2025	4	19	23	2	55	0.9	94	81.5223	69.8873
2025	4	19	23	12	55	0.84	95.6	81.5223	64.8046
2025	4	19	23	22	55	0.84	97.2	81.5223	64.5505
2025	4	19	23	32	55	0.82	97.3	81.5223	63.2798
2025	4	19	23	42	55	0.8	97.1	81.5223	61.5009
2025	4	19	23	52	55	0.81	97	81.5223	62.0092

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	20	0	2	55	0.83	96.8	81.5223	63.7881
2025	4	20	0	12	55	0.84	96.5	81.5223	64.8047
2025	4	20	0	22	55	0.83	93.9	81.5223	63.7882
2025	4	20	0	32	55	0.81	93.9	81.5223	62.7716
2025	4	20	0	42	55	0.81	98.1	81.5223	62.2634
2025	4	20	0	52	55	0.82	96.2	81.5223	62.7717
2025	4	20	1	2	55	0.81	96.1	81.5223	62.0093
2025	4	20	1	12	55	0.84	97.6	81.5223	64.8048
2025	4	20	1	22	55	0.87	94.7	81.5223	67.3461
2025	4	20	1	32	55	0.84	96.7	81.5223	64.8048
2025	4	20	1	42	55	0.83	97.3	81.5223	63.7882
2025	4	20	1	52	55	0.86	97	81.5223	65.8213
2025	4	20	2	2	55	0.8	96.1	81.5223	61.501
2025	4	20	2	12	55	0.79	97.9	81.5223	60.4845
2025	4	20	2	22	55	0.83	96.8	81.5223	64.0424
2025	4	20	2	32	55	0.83	96.8	81.5223	64.0424
2025	4	20	2	42	55	0.88	97.3	81.5223	67.6003
2025	4	20	2	52	55	0.84	96.8	81.5223	64.2965
2025	4	20	3	2	55	0.83	96.8	81.5223	63.7882
2025	4	20	3	12	55	0.81	95.4	81.5223	62.2634
2025	4	20	3	22	55	0.83	98	81.5223	63.5341
2025	4	20	3	32	55	0.84	98	81.5223	64.8048
2025	4	20	3	42	55	0.83	95.5	81.5879	63.8419
2025	4	20	3	52	55	0.86	95	81.5879	66.3854
2025	4	20	4	2	55	0.84	94.9	81.5879	64.8593
2025	4	20	4	12	55	0.87	95.6	81.5879	67.1484
2025	4	20	4	22	55	0.84	97.8	81.5879	64.8593
2025	4	20	4	32	55	0.84	95.8	81.5879	64.6049
2025	4	20	4	42	55	0.86	97.9	81.5879	66.3853
2025	4	20	4	52	55	0.85	95.5	81.5879	65.8766
2025	4	20	5	2	55	0.81	96.1	81.5879	62.3157
2025	4	20	5	12	55	0.89	96.5	81.5879	68.9288
2025	4	20	5	22	55	0.83	93.9	81.5879	63.8418
2025	4	20	5	32	55	0.82	94.1	81.5879	63.5875
2025	4	20	5	42	55	0.81	96	81.5879	62.8244
2025	4	20	5	52	55	0.81	95.1	81.5879	62.8244
2025	4	20	6	2	55	0.82	96.9	81.5879	62.8244
2025	4	20	6	12	55	0.87	96.5	81.5879	66.6396
2025	4	20	6	22	55	0.82	98	81.5879	63.3331
2025	4	20	6	32	55	0.8	97.3	81.5879	61.807
2025	4	20	6	42	55	0.87	95.4	81.5879	66.8939
2025	4	20	6	52	55	0.84	96.3	81.5879	64.3504
2025	4	20	7	2	55	0.81	93.7	81.5879	62.5699
2025	4	20	7	12	55	0.83	98	81.5879	63.5873
2025	4	20	7	22	55	0.83	95.2	81.5879	64.3503
2025	4	20	7	32	55	0.83	96.8	81.5879	63.5872
2025	4	20	7	42	55	0.81	96.8	81.5879	62.0611
2025	4	20	7	52	55	0.84	97	81.5879	64.3502

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	20	8	2	55	0.84	96.8	81.6535	64.4042
2025	4	20	8	12	55	0.8	96.1	81.6535	61.8585
2025	4	20	8	22	55	0.81	95.6	81.6535	62.6221
2025	4	20	8	32	55	0.81	95.4	81.6535	62.3675
2025	4	20	8	42	55	0.81	97.2	81.6535	62.3675
2025	4	20	8	52	55	0.83	96.3	81.6535	64.1494
2025	4	20	9	2	55	0.87	96.5	81.6535	67.4586
2025	4	20	9	12	55	0.82	95.5	81.6535	63.131
2025	4	20	9	22	55	0.83	95.7	81.6535	64.1492
2025	4	20	9	32	55	0.85	95.3	81.6535	65.931
2025	4	20	9	42	55	0.84	93.6	81.6535	65.1673
2025	4	20	9	52	55	0.83	97	81.6535	63.8944
2025	4	20	10	2	55	0.86	96.4	81.6535	65.9308
2025	4	20	10	12	55	0.83	96.3	81.7192	64.2027
2025	4	20	10	22	55	0.84	98.6	81.7192	64.2027
2025	4	20	10	32	55	0.82	96.2	81.7192	63.4383
2025	4	20	10	42	55	0.84	97	81.7192	64.4573
2025	4	20	10	52	55	0.88	97.5	81.7192	67.5145
2025	4	20	11	2	55	0.85	97.1	81.7192	65.2215
2025	4	20	11	12	55	0.81	99.1	81.7192	61.9094
2025	4	20	11	22	55	0.84	98.4	81.7192	64.2023
2025	4	20	11	32	55	0.82	94.8	81.7192	63.6927
2025	4	20	11	42	55	0.8	98.1	81.7192	61.1449
2025	4	20	11	52	55	0.81	97.2	81.7192	62.4188
2025	4	20	12	2	55	0.85	98	81.7192	65.2212
2025	4	20	12	12	55	0.84	95.8	81.7848	64.7659
2025	4	20	12	22	55	0.81	96.5	81.6535	62.6208
2025	4	20	12	32	55	0.86	95.7	81.6535	66.1845
2025	4	20	12	42	55	0.84	96	81.6535	64.9117
2025	4	20	12	52	55	0.81	95.5	81.6535	62.8752
2025	4	20	13	2	55	0.81	96.1	81.7192	62.1637
2025	4	20	13	12	55	0.81	95.4	81.6535	62.3661
2025	4	20	13	22	55	0.8	94.5	81.6535	61.6024
2025	4	20	13	32	55	0.83	96.8	81.5879	63.8397
2025	4	20	13	42	55	0.87	97.4	81.5879	66.8918
2025	4	20	13	52	55	0.84	95.4	81.6535	64.6569
2025	4	20	14	2	55	0.83	97.7	81.5879	63.5853
2025	4	20	14	12	55	0.81	95.4	81.6535	62.3659
2025	4	20	14	22	55	0.86	95.7	81.6535	66.4388
2025	4	20	14	32	55	0.85	94.9	81.6535	65.9296
2025	4	20	14	42	55	0.82	98.1	81.6535	62.6204
2025	4	20	14	52	55	0.84	95.8	81.6535	64.6569
2025	4	20	15	2	55	0.84	96.7	81.7192	64.7111
2025	4	20	15	12	55	0.83	99.3	81.5879	63.8396
2025	4	20	15	22	55	0.81	95.8	81.6535	62.6204
2025	4	20	15	32	55	0.84	96	81.6535	64.9114
2025	4	20	15	42	55	0.79	93.3	81.6535	61.3477
2025	4	20	15	52	55	0.84	97.4	81.5223	64.5483

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	20	16	2	55	0.81	95.5	81.5223	62.7694
2025	4	20	16	12	55	0.83	95.6	81.5223	64.2942
2025	4	20	16	22	55	0.82	97.1	81.5223	63.2777
2025	4	20	16	32	55	0.83	96.8	81.6535	63.6387
2025	4	20	16	42	55	0.82	95.1	81.5879	63.0767
2025	4	20	16	52	55	0.8	97	81.5879	61.805
2025	4	20	17	2	55	0.84	96.3	81.5879	64.3484
2025	4	20	17	12	55	0.84	98.1	81.5879	64.3485
2025	4	20	17	22	55	0.84	96	81.5879	64.8572
2025	4	20	17	32	55	0.82	97.5	81.5223	63.278
2025	4	20	17	42	55	0.83	97.1	81.6535	63.639
2025	4	20	17	52	55	0.84	98.4	81.5879	64.0943
2025	4	20	18	2	55	0.82	97.8	81.5879	62.8226
2025	4	20	18	12	55	0.82	96.6	81.5879	63.3313
2025	4	20	18	22	55	0.81	100.3	81.6535	61.8572
2025	4	20	18	32	55	0.83	96.1	81.6535	64.4029
2025	4	20	18	42	55	0.82	96.4	81.5879	63.3315
2025	4	20	18	52	55	0.84	97.7	81.6535	64.4029
2025	4	20	19	2	55	0.84	95.8	81.6535	64.6575
2025	4	20	19	12	55	0.84	95.8	81.5879	65.112
2025	4	20	19	22	55	0.82	96.7	81.5879	62.8229
2025	4	20	19	32	55	0.84	96	81.5879	64.8577
2025	4	20	19	42	55	0.85	95.5	81.5879	65.8752
2025	4	20	19	52	55	0.82	96.9	81.5879	63.3318
2025	4	20	20	2	55	0.82	96.2	81.5879	63.3318
2025	4	20	20	12	55	0.83	96.1	81.5879	63.8406
2025	4	20	20	22	55	0.82	98.6	81.5223	62.5163
2025	4	20	20	32	55	0.84	95.6	81.5223	64.5494
2025	4	20	20	42	55	0.81	96	81.5223	62.5164
2025	4	20	20	52	55	0.83	95.5	81.5223	63.7871
2025	4	20	21	2	55	0.84	95.8	81.5223	64.5495
2025	4	20	21	12	55	0.84	97.9	81.5879	64.3495
2025	4	20	21	22	55	0.8	97.1	81.5879	61.2974
2025	4	20	21	32	55	0.87	97.6	81.5879	66.893
2025	4	20	21	42	55	0.88	98.1	81.5879	67.9105
2025	4	20	21	52	55	0.86	95.1	81.5879	66.1301
2025	4	20	22	2	55	0.87	96.7	81.5879	67.1475
2025	4	20	22	12	55	0.84	94.5	81.5879	64.604
2025	4	20	22	22	55	0.83	96.3	81.5879	64.0954
2025	4	20	22	32	55	0.84	97	81.5879	64.6041
2025	4	20	22	42	55	0.83	96.1	81.5223	63.7874
2025	4	20	22	52	55	0.85	97.1	81.5879	65.1129
2025	4	20	23	2	55	0.83	97.3	81.5223	63.7875
2025	4	20	23	12	55	0.8	95.4	81.5879	62.0607
2025	4	20	23	22	55	0.9	96.1	81.5223	69.1243
2025	4	20	23	32	55	0.87	94.5	81.5223	67.3454
2025	4	20	23	42	55	0.87	97.2	81.5223	66.8372
2025	4	20	23	52	55	0.82	95.9	81.5223	63.5335

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	21	0	2	55	0.85	96.9	81.5223	65.0583
2025	4	21	0	12	55	0.85	95.3	81.5223	65.8207
2025	4	21	0	22	55	0.82	94.6	81.5223	63.5335
2025	4	21	0	32	55	0.81	94.9	81.5223	62.517
2025	4	21	0	42	55	0.84	95.8	81.5223	65.0583
2025	4	21	0	52	55	0.84	97.8	81.5223	64.5501
2025	4	21	1	2	55	0.84	97	81.5223	64.2959
2025	4	21	1	12	55	0.84	96.5	81.5223	64.2959
2025	4	21	1	22	55	0.87	96.5	81.5223	66.8373
2025	4	21	1	32	55	0.86	96.6	81.5223	66.329
2025	4	21	1	42	55	0.86	95.7	81.5223	66.5831
2025	4	21	1	52	55	0.84	95.4	81.5223	64.5501
2025	4	21	2	2	55	0.85	97.8	81.5223	65.3125
2025	4	21	2	12	55	0.88	98.1	81.5223	67.5997
2025	4	21	2	22	55	0.88	94.1	81.5223	67.8538
2025	4	21	2	32	55	0.85	95.7	81.5223	65.8207
2025	4	21	2	42	55	0.86	97.9	81.5223	66.0749
2025	4	21	2	52	55	0.82	95.1	81.5223	63.0253
2025	4	21	3	2	55	0.86	97.2	81.5223	66.0749
2025	4	21	3	12	55	0.86	96.8	81.5223	66.329
2025	4	21	3	22	55	0.86	98.1	81.5223	65.8207
2025	4	21	3	32	55	0.83	95	81.5223	64.2959
2025	4	21	3	42	55	0.82	94.6	81.5223	63.5335
2025	4	21	3	52	55	0.83	95.6	81.5223	64.2959
2025	4	21	4	2	55	0.85	96	81.5223	65.3124
2025	4	21	4	12	55	0.86	96.8	81.5223	66.329
2025	4	21	4	22	55	0.84	95.8	81.5223	64.8042
2025	4	21	4	32	55	0.89	97.2	81.5223	68.6162
2025	4	21	4	42	55	0.82	96.7	81.5223	63.0252
2025	4	21	4	52	55	0.85	98.9	81.5223	65.0583
2025	4	21	5	2	55	0.85	95.8	81.5223	65.3124
2025	4	21	5	12	55	0.88	94.7	81.5223	67.8538
2025	4	21	5	22	55	0.87	98	81.5223	66.5831
2025	4	21	5	32	55	0.85	95.8	81.5223	65.3124
2025	4	21	5	42	55	0.83	95.7	81.5223	64.0417
2025	4	21	5	52	55	0.85	95.8	81.5223	65.5665
2025	4	21	6	2	55	0.82	94.4	81.5223	63.2793
2025	4	21	6	12	55	0.83	95.4	81.5223	64.2958
2025	4	21	6	22	55	0.83	95.9	81.5879	64.3499
2025	4	21	6	32	55	0.8	97.3	81.5879	61.8064
2025	4	21	6	42	55	0.83	96.8	81.5879	63.5868
2025	4	21	6	52	55	0.83	96.1	81.5879	64.3498
2025	4	21	7	2	55	0.86	97.5	81.5879	65.8759
2025	4	21	7	12	55	0.86	97	81.5879	66.3845
2025	4	21	7	22	55	0.83	98	81.5879	63.5867
2025	4	21	7	32	55	0.86	99	81.5879	65.6214
2025	4	21	7	42	55	0.86	97.9	81.5879	66.13
2025	4	21	7	52	55	0.86	94.8	81.5879	66.13

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	21	8	2	55	0.85	95.5	81.6535	65.9309
2025	4	21	8	12	55	0.81	94	81.6535	62.6216
2025	4	21	8	22	55	0.81	97.4	81.6535	62.6216
2025	4	21	8	32	55	0.81	94.6	81.6535	62.6215
2025	4	21	8	42	55	0.85	95.3	81.6535	65.9307
2025	4	21	8	52	55	0.85	96.9	81.7192	65.7313
2025	4	21	9	2	55	0.82	95.9	81.7192	63.693
2025	4	21	9	12	55	0.83	95.7	81.7192	63.9477
2025	4	21	9	22	55	0.84	96.7	81.7192	64.712
2025	4	21	16	15	24	24.79	97.2	7.592	62.6726
2025	4	21	16	25	24	24.74	93.2	7.592	62.9273
2025	4	21	16	35	24	26.81	95.1	7.5859	67.9656
2025	4	21	16	45	24	25.75	96.2	7.5859	65.1655
2025	4	21	16	55	24	25.28	96.8	7.5859	63.8928
2025	4	21	17	5	24	25.63	92.9	7.5859	65.1656
2025	4	21	17	15	24	26.21	97.2	7.592	66.2394
2025	4	21	17	25	24	24.75	96.3	7.5859	62.6201
2025	4	21	17	35	24	24.58	94.7	7.5859	62.3656
2025	4	21	17	45	24	25.7	98.7	7.5859	64.6566
2025	4	21	17	55	24	25.4	97.2	7.5859	64.1475
2025	4	21	18	5	24	25.6	97.2	7.5859	64.6566
2025	4	21	18	15	24	25.63	97.6	7.5859	64.6567
2025	4	21	18	25	24	24.21	97.6	7.592	61.1442
2025	4	21	18	35	24	25.04	93.4	7.592	63.692
2025	4	21	18	45	24	25.15	96.2	7.592	63.692
2025	4	21	18	55	24	25.59	97	7.592	64.7111
2025	4	21	19	5	24	27.29	94.6	7.592	69.297
2025	4	21	19	15	24	25.44	96.1	7.592	64.4564
2025	4	21	19	25	24	26.07	96.6	7.592	65.9851
2025	4	21	19	35	24	24.95	96.2	7.592	63.1827
2025	4	21	19	45	24	24.65	96.3	7.592	62.4184
2025	4	21	19	55	24	25.48	96.8	7.5859	64.4025
2025	4	21	20	5	24	24.84	96	7.5859	62.8752
2025	4	21	20	15	24	26.14	95.9	7.5859	66.1845
2025	4	21	20	25	24	24.55	96.3	7.592	62.1638
2025	4	21	20	35	24	26.37	96.5	7.592	66.7497
2025	4	21	20	45	24	25.22	95.7	7.592	63.9473
2025	4	21	20	55	24	26	97.1	7.592	65.7307
2025	4	21	21	5	24	26.35	97.9	7.592	66.4951
2025	4	21	21	15	24	24.93	97.8	7.5859	62.8755
2025	4	21	21	25	24	25.53	97.7	7.5859	64.4029
2025	4	21	21	35	24	25.44	96.1	7.5859	64.403
2025	4	21	21	45	24	26.08	96.8	7.5859	65.9304
2025	4	21	21	55	24	25.78	96.7	7.5859	65.1667
2025	4	21	22	5	24	25.96	96.4	7.5859	65.6759
2025	4	21	22	15	24	26.58	96.7	7.5859	67.2033
2025	4	21	22	25	24	25.5	97.2	7.5859	64.4032
2025	4	21	22	35	24	25.1	95	7.5859	63.6395

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	21	22	45	24	25.64	96	7.5859	64.9123
2025	4	21	22	55	24	26.08	96.8	7.5859	65.9306
2025	4	21	23	5	24	25.73	95.8	7.5859	65.1669
2025	4	21	23	15	24	26.35	96.1	7.5859	66.6943
2025	4	21	23	25	24	25.74	97.8	7.5859	64.9124
2025	4	21	23	35	24	24.88	98.6	7.5859	62.6214
2025	4	21	23	45	24	26.08	96.8	7.5859	65.9307
2025	4	21	23	55	24	24.85	96.2	7.5859	62.8761
2025	4	22	0	5	24	26.45	97.8	7.5859	66.6945
2025	4	22	0	15	24	26.45	97.8	7.5859	66.6945
2025	4	22	0	25	24	26.62	95.4	7.5859	67.4582
2025	4	22	0	35	24	25.89	94.7	7.5859	65.6763
2025	4	22	0	45	24	25.63	95.8	7.5859	64.9126
2025	4	22	0	55	24	25.73	97.6	7.5859	64.9126
2025	4	22	1	5	24	26.73	95.6	7.5859	67.7128
2025	4	22	1	15	24	26.02	97.5	7.5859	65.6763
2025	4	22	1	25	24	25.99	94.9	7.5859	65.9309
2025	4	22	1	35	24	25.64	97.8	7.5859	64.6581
2025	4	22	1	45	24	25.44	97.9	7.5859	64.149
2025	4	22	1	55	24	27.33	97.4	7.5859	68.9856
2025	4	22	2	5	24	26.63	95.6	7.5859	67.4583
2025	4	22	2	15	24	26.7	97.1	7.5859	67.4583
2025	4	22	2	25	24	25.24	96.1	7.5859	63.8944
2025	4	22	2	35	24	27.53	95.6	7.5859	69.7493
2025	4	22	2	45	24	26.32	95.5	7.5859	66.6945
2025	4	22	2	55	24	26.21	95.3	7.5859	66.44
2025	4	22	3	5	24	25.5	95	7.5859	64.6581
2025	4	22	3	15	24	26	97.1	7.5859	65.6763
2025	4	22	3	25	24	24.79	97.2	7.5859	62.6216
2025	4	22	3	35	24	25.23	97.7	7.5859	63.6398
2025	4	22	3	45	24	25.59	94.9	7.5859	64.9126
2025	4	22	3	55	24	25.89	96.9	7.5859	65.4217
2025	4	22	4	5	24	25.53	95.8	7.5859	64.658
2025	4	22	4	15	24	26.49	96.9	7.5859	66.9491
2025	4	22	4	25	24	25.73	97.6	7.5859	64.9126
2025	4	22	4	35	24	25.54	97.9	7.5859	64.4035
2025	4	22	4	45	24	23.97	94.3	7.5859	60.8396
2025	4	22	4	55	24	26.06	96.4	7.5859	65.9308
2025	4	22	5	5	24	25.61	97.4	7.5859	64.658
2025	4	22	5	15	24	26.62	98.9	7.5859	66.949
2025	4	22	5	25	24	25.64	96	7.5859	64.9125
2025	4	22	5	35	24	25.24	96.1	7.592	63.9479
2025	4	22	5	45	24	25.99	94.9	7.592	65.9861
2025	4	22	5	55	24	25.66	96.5	7.592	64.967
2025	4	22	6	5	24	26.14	97.7	7.592	65.9861
2025	4	22	6	15	24	25.75	98	7.592	64.967
2025	4	22	6	25	24	24.89	94.8	7.592	63.1836
2025	4	22	6	35	24	26.26	96.3	7.592	66.4957

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	22	6	45	24	25.91	97.3	7.592	65.4765
2025	4	22	6	55	24	25.89	94.7	7.592	65.7313
2025	4	22	7	5	24	25.33	97.7	7.592	63.9479
2025	4	22	7	15	24	26.1	97	7.592	65.9861
2025	4	22	7	25	24	25.73	95.8	7.592	65.2218
2025	4	22	7	35	24	25.93	95.8	7.592	65.7313
2025	4	22	7	45	24	25.96	96.4	7.592	65.7312
2025	4	22	7	55	24	25.09	97.1	7.592	63.4383
2025	4	22	8	5	24	24.91	97.4	7.592	62.9287
2025	4	22	8	15	24	26.1	95.1	7.5981	66.2963
2025	4	22	8	25	24	25.3	95.2	7.5981	64.2563
2025	4	22	8	35	24	25.91	97.3	7.5981	65.5312
2025	4	22	8	45	24	26.05	96.2	7.5981	66.0411
2025	4	22	8	55	24	26.58	96.7	7.5981	67.316
2025	4	22	9	5	24	26.37	96.5	7.5981	66.806
2025	4	22	9	15	24	24.84	96	7.5981	62.9812
2025	4	22	9	25	24	26.59	94.7	7.6041	67.6275
2025	4	22	9	35	24	26.52	97.4	7.6041	67.117
2025	4	22	9	45	24	26.15	97.9	7.6041	66.0962
2025	4	22	9	55	24	26.03	95.7	7.6041	66.0961
2025	4	22	10	5	24	25.09	97.1	7.6041	63.5441
2025	4	22	10	15	24	25.41	95.4	7.6041	64.5648
2025	4	22	10	25	24	25.65	98.1	7.6041	64.82
2025	4	22	10	35	24	25.26	94.1	7.6041	64.3095
2025	4	22	10	45	24	25.7	97.2	7.6041	65.0751
2025	4	22	10	55	24	25.19	97.1	7.6041	63.799
2025	4	22	11	5	24	25.22	99.1	7.6041	63.5438
2025	4	22	11	15	24	25.45	96.3	7.6102	64.6186
2025	4	22	11	25	24	26.53	97.6	7.6102	67.1726
2025	4	22	11	35	24	24.72	97.7	7.6041	62.5228
2025	4	22	11	45	24	26.21	97.2	7.6041	66.3507
2025	4	22	11	55	24	26.83	95.6	7.6102	68.1941
2025	4	22	12	5	24	24.95	96.2	7.6041	63.2882
2025	4	22	12	15	24	25.83	95.8	7.6102	65.6399
2025	4	22	12	25	24	25.33	95.9	7.6041	64.3089
2025	4	22	12	35	24	24.93	95.8	7.6041	63.2881
2025	4	22	12	45	24	25.97	94.2	7.6041	66.0952
2025	4	22	12	55	24	24.69	94.9	7.6041	62.7776
2025	4	22	13	5	24	24.71	95.3	7.6102	62.8302
2025	4	22	13	15	24	25.53	95.8	7.6041	64.8191
2025	4	22	13	25	24	25.5	97.2	7.6041	64.5638
2025	4	22	13	35	24	25.5	97.2	7.5981	64.5097
2025	4	22	13	45	24	24.81	97.4	7.592	62.6722
2025	4	22	13	55	24	25.38	94.5	7.5981	64.5096
2025	4	22	14	5	24	25.63	97.6	7.6041	64.8189
2025	4	22	14	15	24	24.63	95.8	7.6041	62.5221
2025	4	22	14	25	24	25.6	95.2	7.5981	65.0195
2025	4	22	14	35	24	24.51	95.4	7.6041	62.2668

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	22	14	45	24	25.24	96.1	7.5981	63.9995
2025	4	22	14	55	24	24.76	93.9	7.6041	63.0324
2025	4	22	15	5	24	25.96	96.4	7.5981	65.7844
2025	4	22	15	15	24	24.56	96.5	7.5981	62.2147
2025	4	22	15	25	24	25.11	95.3	7.5981	63.7445
2025	4	22	15	35	24	24.75	96.3	7.5981	62.7246
2025	4	22	15	45	24	25.11	95.3	7.6041	63.7979
2025	4	22	15	55	24	25.49	94.7	7.5859	64.6558
2025	4	22	16	5	24	25.99	96.9	7.5981	65.7843
2025	4	22	16	15	24	24.72	95.6	7.6041	62.7772
2025	4	22	16	25	24	25.44	96.1	7.592	64.4554
2025	4	22	16	35	24	25.69	94.7	7.592	65.2197
2025	4	22	16	45	24	25.82	97.6	7.592	65.2198
2025	4	22	16	55	24	26.14	95.9	7.592	66.2388
2025	4	22	17	5	24	25.9	97.1	7.592	65.4746
2025	4	22	17	15	24	25.37	98.4	7.5981	63.9996
2025	4	22	17	25	24	26.12	95.5	7.592	66.2389
2025	4	22	17	35	24	24.8	95.1	7.5981	62.9797
2025	4	22	17	45	24	25.95	98	7.592	65.4746
2025	4	22	17	55	24	25.59	97	7.5859	64.6561
2025	4	22	18	5	24	25.89	94.7	7.5859	65.6743
2025	4	22	18	15	24	26.19	94.8	7.5859	66.438
2025	4	22	18	25	24	25.98	94.6	7.592	65.9843
2025	4	22	18	35	24	25.84	96	7.5859	65.4198
2025	4	22	18	45	24	26.04	96	7.592	65.9843
2025	4	22	18	55	24	26.16	98.1	7.5981	66.0397
2025	4	22	19	5	24	25.71	95.4	7.592	65.2201
2025	4	22	19	15	24	25.53	95.8	7.5981	64.7649
2025	4	22	19	25	24	26.65	96	7.5981	67.5697
2025	4	22	19	35	24	24.88	94.6	7.5981	63.2351
2025	4	22	19	45	24	25.84	96	7.5981	65.53
2025	4	22	19	55	24	26.34	93.3	7.5981	67.0599
2025	4	22	20	5	24	25.63	97.6	7.5981	64.7651
2025	4	22	20	15	24	25.17	94.3	7.5981	64.0002
2025	4	22	20	25	24	25.86	96.4	7.5981	65.5301
2025	4	22	20	35	24	26.2	97	7.592	66.2395
2025	4	22	20	45	24	26.53	95.6	7.592	67.2587
2025	4	22	20	55	24	26.81	95.1	7.592	68.023
2025	4	22	21	5	24	25.73	97.6	7.592	64.9658
2025	4	22	21	15	24	25.28	96.8	7.592	63.9468
2025	4	22	21	25	24	25.84	96	7.592	65.4755
2025	4	22	21	35	24	25.09	97.1	7.592	63.4374
2025	4	22	21	45	24	26.45	96.1	7.592	67.0042
2025	4	22	21	55	24	26.68	96.7	7.592	67.5137
2025	4	22	22	5	24	24.19	97.1	7.5859	61.0933
2025	4	22	22	15	24	25.58	96.7	7.592	64.7114
2025	4	22	22	25	24	26.41	97.2	7.592	66.7495
2025	4	22	22	35	24	25.26	96.4	7.592	63.9471

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	22	22	45	24	26.58	96.7	7.592	67.2591
2025	4	22	22	55	24	25.22	95.7	7.592	63.9471
2025	4	22	23	5	24	25.75	96.2	7.592	65.221
2025	4	22	23	15	24	25.06	96.4	7.592	63.4377
2025	4	22	23	25	24	26.16	96.4	7.592	66.2401
2025	4	22	23	35	24	25.34	96.1	7.5859	64.1482
2025	4	22	23	45	24	25.75	98	7.592	64.9663
2025	4	22	23	55	24	26.68	96.7	7.592	67.514
2025	4	23	0	5	24	26.26	93.7	7.5859	66.6938
2025	4	23	0	15	24	25.45	96.3	7.592	64.4568
2025	4	23	0	25	24	25.48	94.5	7.5859	64.6573
2025	4	23	0	35	24	26.28	96.8	7.5859	66.4393
2025	4	23	0	45	24	26.26	96.3	7.5859	66.4393
2025	4	23	0	55	24	26.59	94.7	7.5859	67.4575
2025	4	23	1	5	24	25.61	95.4	7.5859	64.912
2025	4	23	1	15	24	26.93	97.5	7.5859	67.9666
2025	4	23	1	25	24	25.17	96.6	7.5859	63.6392
2025	4	23	1	35	24	25.31	95.4	7.5859	64.1483
2025	4	23	1	45	24	24.87	94.2	7.5859	63.1301
2025	4	23	1	55	24	24.38	94.7	7.5859	61.8573
2025	4	23	2	5	24	25.69	96.9	7.5859	64.912
2025	4	23	2	15	24	25.33	95.9	7.5859	64.1483
2025	4	23	2	25	24	26.58	96.7	7.5859	67.203
2025	4	23	2	35	24	26.16	96.4	7.5859	66.1847
2025	4	23	2	45	24	25.29	97	7.5859	63.8937
2025	4	23	2	55	24	25.94	97.8	7.5859	65.4211
2025	4	23	3	5	24	23.26	93.9	7.5859	59.0572
2025	4	23	3	15	24	25.89	96.9	7.5859	65.4211
2025	4	23	3	25	24	26.16	96.4	7.5859	66.1847
2025	4	23	3	35	24	26.18	94.4	7.5859	66.4393
2025	4	23	3	45	24	25.5	97.2	7.5859	64.4028
2025	4	23	3	55	24	24.04	98.1	7.5859	60.5845
2025	4	23	4	5	24	25.94	96	7.5859	65.6756
2025	4	23	4	15	24	25.59	97	7.5859	64.6573
2025	4	23	4	25	24	25.34	96.1	7.5859	64.1482
2025	4	23	4	35	24	25.28	96.8	7.5859	63.8937
2025	4	23	4	45	24	26.09	94.8	7.5859	66.1847
2025	4	23	4	55	24	25.91	95.3	7.592	65.7307
2025	4	23	5	5	24	25.01	95.3	7.592	63.4377
2025	4	23	5	15	24	26.03	95.7	7.592	65.9854
2025	4	23	5	25	24	24.96	93.9	7.592	63.4377
2025	4	23	5	35	24	26.03	95.7	7.592	65.9854
2025	4	23	5	45	24	25.59	97	7.592	64.7116
2025	4	23	5	55	24	25.22	95.7	7.592	63.9472
2025	4	23	6	5	24	26.78	96.6	7.592	67.7688
2025	4	23	6	15	24	24.53	95.9	7.592	62.1638
2025	4	23	6	25	24	26.56	93.9	7.592	67.514
2025	4	23	6	35	24	24.7	97.2	7.592	62.4186

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	23	6	45	24	25.83	95.8	7.592	65.4758
2025	4	23	6	55	24	26.16	96.4	7.592	66.2401
2025	4	23	7	5	24	25.3	95.2	7.5981	64.2558
2025	4	23	7	15	24	25.27	94.3	7.5981	64.2558
2025	4	23	7	25	24	26.61	95.2	7.5981	67.5706
2025	4	23	7	35	24	26.03	95.7	7.5981	66.0407
2025	4	23	7	45	24	25.94	96	7.5981	65.7857
2025	4	23	7	55	24	26.33	95.7	7.5981	66.8055
2025	4	23	8	5	24	24.32	95.7	7.5981	61.7059
2025	4	23	8	15	24	25.54	97.9	7.5981	64.5106
2025	4	23	8	25	24	26.25	97.9	7.5981	66.2955
2025	4	23	8	35	24	25.68	94.5	7.5981	65.2755
2025	4	23	8	45	24	25.57	94.3	7.6041	65.075
2025	4	23	8	55	24	25.95	96.2	7.5981	65.7854
2025	4	23	9	5	24	26.18	96.8	7.5981	66.2953
2025	4	23	9	15	24	25.4	95.2	7.6041	64.5644
2025	4	23	9	25	24	24.81	95.3	7.6041	63.0332
2025	4	23	9	35	24	25.08	94.6	7.6041	63.7988
2025	4	23	9	45	24	24.24	96.2	7.6041	61.5019
2025	4	23	9	55	24	26.01	97.3	7.6041	65.8402
2025	4	23	10	5	24	25.42	95.6	7.6041	64.5642
2025	4	23	10	15	24	25.75	96.2	7.6041	65.3297
2025	4	23	10	25	24	25.51	97.4	7.6041	64.564
2025	4	23	10	35	24	25.95	98	7.6041	65.5848
2025	4	23	10	45	24	25.62	95.6	7.6041	65.0743
2025	4	23	10	55	24	25.36	93.8	7.6041	64.5639
2025	4	23	11	5	24	25.24	98	7.6041	63.7983
2025	4	23	11	15	24	26.19	98.6	7.6041	66.0949
2025	4	23	11	25	24	26.84	95.8	7.6041	68.1364
2025	4	23	11	35	24	24.45	93.8	7.6041	62.2669
2025	4	23	11	45	24	25.94	96	7.6041	65.8396
2025	4	23	11	55	24	25.57	98.3	7.6041	64.5635
2025	4	23	12	5	24	26.28	96.8	7.6041	66.605
2025	4	23	12	15	24	25.16	96.4	7.6041	63.7979
2025	4	23	12	25	24	27.43	95.6	7.6041	69.6672
2025	4	23	12	35	24	24.8	95.1	7.5981	62.9794
2025	4	23	12	45	24	26.35	97.9	7.5981	66.549
2025	4	23	12	55	24	25.16	96.4	7.5981	63.7442
2025	4	23	13	5	24	24.51	95.4	7.592	62.1622
2025	4	23	13	15	24	26.54	95.8	7.5859	67.201
2025	4	23	13	25	24	26.04	96	7.5859	65.9282
2025	4	23	13	35	24	25.64	96	7.5859	64.91
2025	4	23	13	45	24	24.87	94.4	7.592	63.1811
2025	4	23	13	55	24	25.68	96.7	7.5859	64.9099
2025	4	23	14	5	24	25.55	96.3	7.5859	64.6553
2025	4	23	14	15	24	25.8	95.1	7.5859	65.4189
2025	4	23	14	25	24	25.69	96.9	7.5859	64.9098
2025	4	23	14	35	24	26.14	95.9	7.5859	66.1825

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	23	14	45	24	25.61	95.4	7.5859	64.9098
2025	4	23	14	55	24	25.98	98.4	7.5859	65.4188
2025	4	23	15	5	24	26.6	95	7.5859	67.4552
2025	4	23	15	15	24	25.32	95.7	7.5859	64.1461
2025	4	23	15	25	24	25.84	96	7.5859	65.4188
2025	4	23	15	35	24	25.71	95.4	7.5859	65.1642
2025	4	23	15	45	24	26.34	93	7.5859	66.9461
2025	4	23	15	55	24	27.16	96.1	7.5859	68.7279
2025	4	23	16	5	24	27.04	95.7	7.5859	68.4734
2025	4	23	16	15	24	26.32	99	7.5859	66.1824
2025	4	23	16	25	24	25.66	93.8	7.5859	65.1643
2025	4	23	16	35	24	25.3	95.2	7.5859	64.1461
2025	4	23	16	45	24	24.75	96.3	7.5859	62.6188
2025	4	23	16	55	24	24.78	94.6	7.5798	62.8206
2025	4	23	17	5	24	26.32	97.4	7.5859	66.4371
2025	4	23	17	15	24	25.96	96.4	7.5859	65.6734
2025	4	23	17	25	24	25.54	96.1	7.5798	64.601
2025	4	23	17	35	24	26.14	95.9	7.5798	66.127
2025	4	23	17	45	24	25.21	95.5	7.5798	63.838
2025	4	23	17	55	24	26.99	96.8	7.5798	68.1618
2025	4	23	18	5	24	26.53	95.6	7.5798	67.1445
2025	4	23	18	15	24	26.71	95.2	7.5798	67.6532
2025	4	23	18	25	24	24.8	95.1	7.5798	62.8208
2025	4	23	18	35	24	24.82	92.1	7.5798	63.0752
2025	4	23	18	45	24	26.99	96.8	7.5859	68.2192
2025	4	23	18	55	24	25.9	95.1	7.5798	65.6186
2025	4	23	19	5	24	25.76	94	7.5798	65.3643
2025	4	23	19	15	24	25.8	97.1	7.5798	65.1101
2025	4	23	19	25	24	26.24	95.9	7.5798	66.3818
2025	4	23	19	35	24	27.29	96.7	7.5798	68.9252
2025	4	23	19	45	24	25.11	95.3	7.5798	63.5842
2025	4	23	19	55	24	25.84	96	7.5798	65.3646
2025	4	23	20	5	24	25.95	96.2	7.5798	65.619
2025	4	23	20	15	24	25.35	93.6	7.5798	64.3473
2025	4	23	20	25	24	26.54	95.8	7.5737	67.0887
2025	4	23	20	35	24	26.39	97	7.5798	66.6365
2025	4	23	20	45	24	26.79	94.7	7.5737	67.8511
2025	4	23	20	55	24	26.28	96.8	7.5737	66.3264
2025	4	23	21	5	24	26.82	97.3	7.5737	67.5971
2025	4	23	21	15	24	27.03	97.4	7.5798	68.1627
2025	4	23	21	25	24	26.55	97.8	7.5737	66.8348
2025	4	23	21	35	24	25.9	98.7	7.5737	65.056
2025	4	23	21	45	24	26.56	96.3	7.5798	67.1454
2025	4	23	21	55	24	25.64	96	7.5798	64.8564
2025	4	23	22	5	24	25.95	96.2	7.5798	65.6195
2025	4	23	22	15	24	24.74	96	7.5798	62.5674
2025	4	23	22	25	24	26.75	96	7.5798	67.6542
2025	4	23	22	35	24	25.95	93.5	7.5798	65.8739

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	23	22	45	24	26.26	93.9	7.5859	66.6929
2025	4	23	22	55	24	25.75	96.2	7.5859	65.1657
2025	4	23	23	5	24	26.55	93.5	7.5859	67.4567
2025	4	23	23	15	24	26.15	96.1	7.5859	66.1839
2025	4	23	23	25	24	28.09	96.7	7.5859	71.0205
2025	4	23	23	35	24	26.35	97.9	7.5859	66.4385
2025	4	23	23	45	24	27.49	96.7	7.592	69.5515
2025	4	23	23	55	24	27.56	96.2	7.592	69.8063
2025	4	24	0	5	24	26.58	96.7	7.592	67.2587
2025	4	24	0	15	24	27.33	97.4	7.592	69.0421
2025	4	24	0	25	24	26.75	96	7.592	67.7682
2025	4	24	0	35	24	26.34	95.9	7.592	66.7492
2025	4	24	0	45	24	25.5	98.8	7.5859	64.1477
2025	4	24	0	55	24	26.05	97.9	7.592	65.7301
2025	4	24	1	5	24	26.02	95.5	7.592	65.9849
2025	4	24	1	15	24	26.47	96.5	7.592	67.004
2025	4	24	1	25	24	25.44	96.1	7.592	64.4563
2025	4	24	1	35	24	25.99	96.9	7.592	65.7302
2025	4	24	1	45	24	24.58	94.7	7.592	62.4182
2025	4	24	1	55	24	25.89	96.9	7.5859	65.4205
2025	4	24	2	5	24	26.76	97.9	7.592	67.5135
2025	4	24	2	15	24	26.63	99.1	7.592	67.004
2025	4	24	2	25	24	25.8	95.1	7.592	65.4754
2025	4	24	2	35	24	25.43	97.7	7.592	64.2016
2025	4	24	2	45	24	25.44	96.1	7.592	64.4563
2025	4	24	2	55	24	27.1	97	7.592	68.5326
2025	4	24	3	5	24	26.36	96.3	7.592	66.7492
2025	4	24	3	15	24	26.79	98.4	7.592	67.5135
2025	4	24	3	25	24	25.78	96.7	7.592	65.2206
2025	4	24	3	35	24	25.69	96.9	7.592	64.9658
2025	4	24	3	45	24	26.55	96.1	7.592	67.2587
2025	4	24	3	55	24	26.23	95.7	7.592	66.4944
2025	4	24	4	5	24	26.36	96.3	7.592	66.7492
2025	4	24	4	15	24	26.15	97.9	7.592	65.9849
2025	4	24	4	25	24	26.64	95.8	7.592	67.5135
2025	4	24	4	35	24	26.68	96.7	7.592	67.5135
2025	4	24	4	45	24	25.54	96.1	7.592	64.711
2025	4	24	4	55	24	26.73	95.6	7.592	67.7682
2025	4	24	5	5	24	26.18	94.4	7.592	66.4944
2025	4	24	5	15	24	25.59	94.9	7.592	64.9658
2025	4	24	5	25	24	26.08	96.8	7.592	65.9848
2025	4	24	5	35	24	26.43	95.6	7.592	67.0039
2025	4	24	5	45	24	26.48	94.5	7.592	67.2587
2025	4	24	5	55	24	25.48	96.8	7.592	64.4562
2025	4	24	6	5	24	23.67	94.4	7.592	60.1251
2025	4	24	6	15	24	25.89	94.9	7.5859	65.6749
2025	4	24	6	25	24	26.33	97.6	7.5859	66.4385
2025	4	24	6	35	24	25.21	95.5	7.592	63.9466

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	24	6	45	24	26.69	94.7	7.5859	67.7113
2025	4	24	6	55	24	25.89	96.9	7.5859	65.4203
2025	4	24	7	5	24	26.22	95.5	7.5859	66.4385
2025	4	24	7	15	24	25.33	95.9	7.592	64.2014
2025	4	24	7	25	24	26.75	96	7.592	67.7681
2025	4	24	7	35	24	26.2	97	7.5859	66.1839
2025	4	24	7	45	24	26.26	93.9	7.5859	66.693
2025	4	24	7	55	24	27.19	96.8	7.5859	68.7294
2025	4	24	8	5	24	26.38	96.7	7.5798	66.637
2025	4	24	8	15	24	26.64	95.8	7.5798	67.4
2025	4	24	8	25	24	25.16	96.4	7.5737	63.5314
2025	4	24	8	35	24	27.23	97.4	7.5737	68.6139
2025	4	24	8	45	24	26.09	94.8	7.5737	66.0726
2025	4	24	8	55	24	26.39	97	7.5737	66.5808
2025	4	24	9	5	24	26.2	95	7.5859	66.4382
2025	4	24	9	15	24	26.6	98.6	7.5737	66.8349
2025	4	24	9	25	24	25.57	96.5	7.5737	64.5477
2025	4	24	9	35	24	25.16	96.4	7.5737	63.5312
2025	4	24	9	45	24	26.6	95	7.5737	67.343
2025	4	24	9	55	24	25.97	96.6	7.5737	65.5641
2025	4	24	10	5	24	27.01	95.1	7.5737	68.3594
2025	4	24	10	15	24	26.01	95.3	7.5737	65.8182
2025	4	24	10	25	24	27.2	97	7.5737	68.6135
2025	4	24	10	35	24	26.97	96.4	7.5737	68.1052
2025	4	24	10	45	24	26.35	96.1	7.5737	66.5804
2025	4	24	10	55	24	25.47	94.3	7.5737	64.5474
2025	4	24	11	5	24	26.26	96.3	7.5737	66.3262
2025	4	24	11	15	24	26.58	96.7	7.5737	67.0885
2025	4	24	11	25	24	26.89	94.7	7.5737	68.1049
2025	4	24	11	35	24	26.08	96.8	7.5737	65.8178
2025	4	24	11	45	24	26.01	95.3	7.5737	65.8177
2025	4	24	11	55	24	24.83	95.8	7.5798	62.821
2025	4	24	12	5	24	26.12	99	7.5798	65.6187
2025	4	24	12	15	24	26.41	97.2	7.5798	66.636
2025	4	24	12	25	24	26.59	96.9	7.5737	67.0882
2025	4	24	12	35	24	26.3	97	7.5798	66.3815
2025	4	24	12	45	24	25.9	95.1	7.5798	65.6185
2025	4	24	12	55	24	25.29	97	7.5798	63.8381
2025	4	24	13	5	24	25.4	97.2	7.5737	64.0386
2025	4	24	13	15	24	24.19	95	7.5737	61.2432
2025	4	24	13	25	24	26.73	97.5	7.5798	67.3987
2025	4	24	13	35	24	26.49	96.9	7.5737	66.8338
2025	4	24	13	45	24	25.74	96	7.5798	65.1097
2025	4	24	13	55	24	25.03	95.7	7.5859	63.3825
2025	4	24	14	5	24	25.31	95.4	7.5737	64.0384
2025	4	24	14	15	24	26.43	97.6	7.5798	66.6356
2025	4	24	14	25	24	26.55	97.8	7.5798	66.8899
2025	4	24	14	35	24	26.02	97.5	7.5737	65.5631

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	24	14	45	24	26.18	96.8	7.5737	66.0713
2025	4	24	14	55	24	25.69	94.7	7.5798	65.1095
2025	4	24	15	5	24	25.74	96	7.5859	65.1642
2025	4	24	15	15	24	25.21	95.2	7.5737	63.7842
2025	4	24	15	25	24	24.94	93.2	7.5615	63.1695
2025	4	24	15	35	24	24.76	96.5	7.5798	62.5662
2025	4	24	15	45	24	24.82	95.5	7.5798	62.8205
2025	4	24	15	55	24	25.8	97.1	7.5737	65.0548
2025	4	24	16	5	24	24.85	96.2	7.5798	62.8205
2025	4	24	16	15	24	25.82	95.6	7.5737	65.309
2025	4	24	16	25	24	25.11	95.3	7.5737	63.5301
2025	4	24	16	35	24	25.66	94	7.5798	65.1096
2025	4	24	16	45	24	24.21	95.5	7.5737	61.2431
2025	4	24	16	55	24	24.44	96.1	7.5676	61.6994
2025	4	24	17	5	24	26.57	96.5	7.5737	67.0879
2025	4	24	17	15	24	24.01	95.5	7.5737	60.7349
2025	4	24	17	25	24	24.62	95.6	7.5676	62.2073
2025	4	24	17	35	24	25.5	95.2	7.5676	64.4925
2025	4	24	17	45	24	25.3	95	7.5676	63.9847
2025	4	24	17	55	24	25.11	95.5	7.5737	63.5303
2025	4	24	18	5	24	25.69	96.9	7.5676	64.7465
2025	4	24	18	15	24	26.45	97.8	7.5676	66.5239
2025	4	24	18	25	24	25.7	97.2	7.5737	64.8011
2025	4	24	18	35	24	25.67	94.2	7.5737	65.0552
2025	4	24	18	45	24	24.67	94.2	7.5676	62.4615
2025	4	24	18	55	24	25.48	94.5	7.5737	64.5471
2025	4	24	19	5	24	25	95	7.5676	63.2233
2025	4	24	19	15	24	25.58	96.7	7.5676	64.4929
2025	4	24	19	25	24	23.71	95.6	7.5676	59.9226
2025	4	24	19	35	24	26.45	96.1	7.5615	66.722
2025	4	24	19	45	24	25.5	95.2	7.5676	64.493
2025	4	24	19	55	24	25.38	96.8	7.5676	63.9853
2025	4	24	20	5	24	25.44	96.1	7.5615	64.1852
2025	4	24	20	15	24	26.58	96.7	7.5615	66.9759
2025	4	24	20	25	24	25.99	94.9	7.5554	65.6521
2025	4	24	20	35	24	25.94	97.8	7.5615	65.2001
2025	4	24	20	45	24	26.04	96	7.5554	65.6522
2025	4	24	20	55	24	25.8	95.1	7.5615	65.2002
2025	4	24	21	5	24	26.26	96.3	7.5554	66.1593
2025	4	24	21	15	24	25.1	97.3	7.5615	63.1707
2025	4	24	21	25	24	25.8	97.1	7.5615	64.9466
2025	4	24	21	35	24	25.57	96.5	7.5554	64.385
2025	4	24	21	45	24	25.8	97.1	7.5554	64.892
2025	4	24	21	55	24	25.75	96.2	7.5554	64.892
2025	4	24	22	5	24	25.84	96	7.5554	65.1456
2025	4	24	22	15	24	26.42	95.4	7.5554	66.6665
2025	4	24	22	25	24	25.45	93.6	7.5554	64.3852
2025	4	24	22	35	24	26.08	94.4	7.5554	65.9061

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	24	22	45	24	26.54	95.8	7.5554	66.9201
2025	4	24	22	55	24	24.9	95.1	7.5615	62.9174
2025	4	24	23	5	24	25.5	95.2	7.5554	64.3853
2025	4	24	23	15	24	26.37	99.6	7.5493	65.8507
2025	4	24	23	25	24	25.75	96.2	7.5554	64.8923
2025	4	24	23	35	24	27.08	96.6	7.5493	68.1302
2025	4	24	23	45	24	25.62	95.6	7.5493	64.5844
2025	4	24	23	55	24	26.04	97.7	7.5493	65.3442
2025	4	25	0	5	24	25.98	94.6	7.5493	65.5975
2025	4	25	0	15	24	26.55	96.1	7.5493	66.8639
2025	4	25	0	25	24	26.05	96.2	7.5493	65.5975
2025	4	25	0	35	24	26.01	97.3	7.5493	65.3443
2025	4	25	0	45	24	25.99	94.9	7.5493	65.5976
2025	4	25	0	55	24	26.13	95.7	7.5493	65.8508
2025	4	25	1	5	24	24.68	94.6	7.5493	62.305
2025	4	25	1	15	24	25.52	95.6	7.5493	64.3312
2025	4	25	1	25	24	25.29	97	7.5493	63.5714
2025	4	25	1	35	24	25.45	96.3	7.5493	64.078
2025	4	25	1	45	24	26.88	96.6	7.5493	67.6238
2025	4	25	1	55	24	25.34	96.1	7.5493	63.8247
2025	4	25	2	5	24	25.51	95.4	7.5432	64.277
2025	4	25	2	15	24	25.59	97	7.5432	64.277
2025	4	25	2	25	24	25.1	95	7.5493	63.3182
2025	4	25	2	35	24	25.47	98.4	7.5432	63.7709
2025	4	25	2	45	24	25.64	96	7.5432	64.53
2025	4	25	2	55	24	25.16	96.4	7.5432	63.2647
2025	4	25	3	5	24	27.55	93.3	7.5493	69.65
2025	4	25	3	15	24	26.46	98	7.5493	66.3574
2025	4	25	3	25	24	26.18	94.4	7.5493	66.1041
2025	4	25	3	35	24	25.45	96.3	7.5493	64.0779
2025	4	25	3	45	24	26.31	95.2	7.5493	66.3574
2025	4	25	3	55	24	26.33	97.6	7.5432	66.0483
2025	4	25	4	5	24	25.32	97.5	7.5432	63.5177
2025	4	25	4	15	24	26.05	96.2	7.5432	65.5422
2025	4	25	4	25	24	26.03	95.7	7.5432	65.5422
2025	4	25	4	35	24	25.58	96.7	7.5432	64.2769
2025	4	25	4	45	24	25.59	97	7.5432	64.2769
2025	4	25	4	55	24	26.25	96.1	7.5493	66.104
2025	4	25	5	5	24	25.16	94.1	7.5493	63.5713
2025	4	25	5	15	24	25.54	96.1	7.5432	64.2768
2025	4	25	5	25	24	26.12	97.5	7.5432	65.5421
2025	4	25	5	35	24	25.81	97.3	7.5432	64.7829
2025	4	25	5	45	24	25.27	94.3	7.5432	63.7707
2025	4	25	5	55	24	25.51	95.4	7.5432	64.2768
2025	4	25	6	5	24	24.91	95.3	7.5432	62.7585
2025	4	25	6	15	24	26.02	95.5	7.5432	65.5421
2025	4	25	6	25	24	25.57	96.5	7.5432	64.2768
2025	4	25	6	35	24	26.14	95.9	7.5493	65.8507

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	25	6	45	24	25.13	95.9	7.5493	63.3179
2025	4	25	6	55	24	24.96	94.1	7.5493	63.0647
2025	4	25	7	5	24	25.78	96.7	7.5432	64.7829
2025	4	25	7	15	24	25.77	98.3	7.5432	64.5298
2025	4	25	7	25	24	25.6	95.2	7.5432	64.5298
2025	4	25	7	35	24	25.67	98.3	7.5493	64.331
2025	4	25	7	45	24	25.63	97.6	7.5432	64.2767
2025	4	25	7	55	24	25.09	98.7	7.5493	62.8113
2025	4	25	8	5	24	25.29	94.8	7.5493	63.8244
2025	4	25	8	15	24	26.78	94.5	7.5493	67.6234
2025	4	25	8	25	24	26.13	95.7	7.5493	65.8505
2025	4	25	8	35	24	26.15	96.1	7.5493	65.8505
2025	4	25	8	45	24	25.21	95.2	7.5493	63.571
2025	4	25	8	55	24	26.27	96.6	7.5493	66.1037
2025	4	25	9	5	24	25.85	98	7.5493	64.8373
2025	4	25	9	15	24	25.31	95.4	7.5493	63.8242
2025	4	25	9	25	24	25.74	96	7.5493	64.8373
2025	4	25	9	35	24	24.86	96.5	7.5493	62.5578
2025	4	25	9	45	24	25.4	97.2	7.5493	63.8241
2025	4	25	9	55	24	26.03	95.7	7.5493	65.597
2025	4	25	10	5	24	25.8	97.1	7.5493	64.8371
2025	4	25	10	15	24	25.24	93.4	7.5432	63.7702
2025	4	25	10	25	24	25.24	96.1	7.5493	63.5707
2025	4	25	10	35	24	25.05	96.2	7.5493	63.0641
2025	4	25	10	45	24	25.3	95	7.5554	63.8778
2025	4	25	10	55	24	24.96	94.1	7.5554	63.1173
2025	4	25	11	5	24	25.54	96.1	7.5554	64.3846
2025	4	25	11	15	24	25.65	96.3	7.5554	64.6381
2025	4	25	11	25	24	26.06	94	7.5493	65.8499
2025	4	25	11	35	24	25.54	93.4	7.5554	64.638
2025	4	25	11	45	24	25.3	97.3	7.5493	63.5704
2025	4	25	11	55	24	25.54	93.4	7.5554	64.6379
2025	4	25	12	5	24	25.6	95.2	7.5615	64.6924
2025	4	25	12	15	24	24.33	95.9	7.5554	61.3426
2025	4	25	12	25	24	25.06	96.4	7.5554	63.117
2025	4	25	12	35	24	25.51	95.4	7.5554	64.3843
2025	4	25	12	45	24	25.01	95.3	7.5615	63.1701
2025	4	25	12	55	24	24.75	96.3	7.5554	62.3564
2025	4	25	13	5	24	24.5	95.2	7.5554	61.8494
2025	4	25	13	15	24	25.21	95.5	7.5615	63.6774
2025	4	25	13	25	24	24.31	95.4	7.5554	61.3424
2025	4	25	13	35	24	24.74	96	7.5615	62.4089
2025	4	25	13	45	24	25.43	95.9	7.5554	64.1307
2025	4	25	13	55	24	25.15	96.2	7.5493	63.3168
2025	4	25	14	5	24	25.65	96.3	7.5493	64.5831
2025	4	25	14	15	24	25.73	95.8	7.5432	64.7817
2025	4	25	14	25	24	24.22	95.7	7.5615	61.1403
2025	4	25	14	35	24	24.46	96.6	7.5554	61.5958

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	25	14	45	24	24.83	95.8	7.5554	62.6097
2025	4	25	14	55	24	25.7	97.2	7.5554	64.6376
2025	4	25	15	5	24	24.78	97	7.5493	62.3037
2025	4	25	15	15	24	24.87	94.4	7.5493	62.8102
2025	4	25	15	25	24	25.82	97.6	7.5554	64.8911
2025	4	25	15	35	24	25.78	94.4	7.5493	65.0896
2025	4	25	15	45	24	25.04	93.2	7.5554	63.3702
2025	4	25	15	55	24	24.8	95.1	7.5554	62.6098
2025	4	25	16	5	24	25.26	94.1	7.5493	63.8234
2025	4	25	16	15	24	25.27	96.6	7.5432	63.5165
2025	4	25	16	25	24	25.03	93	7.5432	63.2634
2025	4	25	16	35	24	25.36	96.3	7.5493	63.8234
2025	4	25	16	45	24	24.12	95.7	7.5493	60.7842
2025	4	25	16	55	24	26.87	96.4	7.5432	67.5654
2025	4	25	17	5	24	25.1	97.3	7.5554	63.1169
2025	4	25	17	15	24	24.56	94	7.5676	62.2077
2025	4	25	17	25	24	24.42	95.6	7.5554	61.5961
2025	4	25	17	35	24	25.87	96.7	7.5432	65.035
2025	4	25	17	45	24	25.5	97.2	7.5554	64.131
2025	4	25	17	55	24	25.06	98.3	7.5493	62.8106
2025	4	25	18	5	24	24.75	96.3	7.5432	62.2515
2025	4	25	18	15	24	24.68	97	7.5493	62.0508
2025	4	25	18	25	24	25.76	96.5	7.5432	64.7821
2025	4	25	18	35	24	25.07	96.6	7.5493	63.064
2025	4	25	18	45	24	24.71	95.3	7.5432	62.2517
2025	4	25	18	55	24	25.95	98	7.5493	65.0902
2025	4	25	19	5	24	25.11	95.3	7.5493	63.3174
2025	4	25	19	15	24	25.8	97.1	7.5493	64.8371
2025	4	25	19	25	24	24.4	95.2	7.5432	61.4927
2025	4	25	19	35	24	25.19	94.8	7.5493	63.5708
2025	4	25	19	45	24	25.75	96.2	7.5493	64.8372
2025	4	25	19	55	24	24.27	96.9	7.5371	60.9352
2025	4	25	20	5	24	25.75	93.6	7.5493	65.0906
2025	4	25	20	15	24	25.28	96.8	7.5432	63.5174
2025	4	25	20	25	24	25.22	95.7	7.5554	63.6247
2025	4	25	20	35	24	24.97	94.4	7.5493	63.0646
2025	4	25	20	45	24	24.88	94.6	7.5493	62.8113
2025	4	25	20	55	24	25.16	94.1	7.5493	63.5712
2025	4	25	21	5	24	25.97	96.6	7.5432	65.289
2025	4	25	21	15	24	25.23	97.7	7.5432	63.2646
2025	4	25	21	25	24	24.34	96.1	7.5432	61.2402
2025	4	25	21	35	24	25.73	97.6	7.5493	64.5845
2025	4	25	21	45	24	25.16	96.4	7.5432	63.2647
2025	4	25	21	55	24	25.11	95.5	7.5432	63.2648
2025	4	25	22	5	24	25.1	95	7.5371	63.2114
2025	4	25	22	15	24	25.66	96.5	7.5493	64.5846
2025	4	25	22	25	24	25.84	96	7.5432	65.0363
2025	4	25	22	35	24	25.32	97.5	7.5432	63.518

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	25	22	45	24	25.44	96.1	7.5432	64.0241
2025	4	25	22	55	24	24.35	98.3	7.5371	60.9359
2025	4	25	23	5	24	25.8	95.1	7.531	64.9266
2025	4	25	23	15	24	26.52	97.4	7.5371	66.4986
2025	4	25	23	25	24	26.76	93.9	7.5371	67.51
2025	4	25	23	35	24	26.28	96.8	7.5371	65.993
2025	4	25	23	45	24	24.49	94.9	7.5371	61.6946
2025	4	25	23	55	24	25.44	96.1	7.5432	64.0243
2025	4	26	0	5	24	25.41	95.4	7.5371	63.9703
2025	4	26	0	15	24	26.23	95.7	7.5371	65.9931
2025	4	26	0	25	24	24.93	95.8	7.5371	62.7061
2025	4	26	0	35	24	26.18	94.6	7.5371	65.9931
2025	4	26	0	45	24	25.98	98.4	7.5371	64.9817
2025	4	26	0	55	24	25.98	98.4	7.5371	64.9817
2025	4	26	1	5	24	24.03	96	7.5371	60.4305
2025	4	26	1	15	24	26.33	95.7	7.5371	66.246
2025	4	26	1	25	24	26.37	96.5	7.531	66.19
2025	4	26	1	35	24	26.11	97.3	7.531	65.4321
2025	4	26	1	45	24	25.87	96.7	7.531	64.9269
2025	4	26	1	55	24	24.29	95	7.5371	61.1891
2025	4	26	2	5	24	25.72	95.6	7.531	64.6742
2025	4	26	2	15	24	26.97	96.4	7.531	67.7059
2025	4	26	2	25	24	25.12	97.5	7.531	62.9058
2025	4	26	2	35	24	26.33	97.6	7.531	65.9374
2025	4	26	2	45	24	26.13	95.7	7.531	65.6848
2025	4	26	2	55	24	25.73	97.6	7.5371	64.4761
2025	4	26	3	5	24	26.87	96.4	7.531	67.4532
2025	4	26	3	15	24	26.11	95.3	7.531	65.6848
2025	4	26	3	25	24	25.34	97.9	7.531	63.4111
2025	4	26	3	35	24	25.47	96.5	7.531	63.9163
2025	4	26	3	45	24	25.26	96.4	7.531	63.4111
2025	4	26	3	55	24	25.82	95.6	7.5371	64.9818
2025	4	26	4	5	24	25.43	95.9	7.5371	63.9704
2025	4	26	4	15	24	26.3	95	7.531	66.19
2025	4	26	4	25	24	26.29	98.5	7.531	65.6847
2025	4	26	4	35	24	26.18	96.8	7.5371	65.7403
2025	4	26	4	45	24	25.99	96.9	7.5371	65.2346
2025	4	26	4	55	24	25.24	96.1	7.5371	63.4646
2025	4	26	5	5	24	25.99	96.9	7.5371	65.2346
2025	4	26	5	15	24	25.29	94.8	7.5371	63.7175
2025	4	26	5	25	24	25.51	97.4	7.5371	63.9703
2025	4	26	5	35	24	25.34	96.1	7.531	63.6636
2025	4	26	5	45	24	26.23	95.7	7.5371	65.9931
2025	4	26	5	55	24	25.94	96	7.5371	65.2346
2025	4	26	6	5	24	25.31	95.4	7.5371	63.7175
2025	4	26	6	15	24	25.49	97	7.5371	63.9703
2025	4	26	6	25	24	26.02	95.5	7.5371	65.4874
2025	4	26	6	35	24	25.91	95.3	7.5371	65.2346

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	26	6	45	24	26.07	96.6	7.5432	65.5427
2025	4	26	6	55	24	24.48	94.7	7.5371	61.6947
2025	4	26	7	5	24	25.85	98	7.5371	64.7288
2025	4	26	7	15	24	26.83	95.6	7.5371	67.5102
2025	4	26	7	25	24	27.16	96.1	7.5371	68.2687
2025	4	26	7	35	24	25.91	97.3	7.5371	64.9817
2025	4	26	7	45	24	25.69	94.9	7.5371	64.7288
2025	4	26	7	55	24	26.13	95.7	7.5371	65.7402
2025	4	26	8	5	24	25.03	95.7	7.5432	63.0121
2025	4	26	8	15	24	25.66	96.5	7.5432	64.5304
2025	4	26	8	25	24	25.01	97.4	7.5432	62.759
2025	4	26	8	35	24	25.54	97.9	7.5432	64.0243
2025	4	26	8	45	24	26.38	96.7	7.5432	66.3018
2025	4	26	8	55	24	24.98	98.5	7.5432	62.5059
2025	4	26	9	5	24	24.1	95.2	7.5432	60.7344
2025	4	26	9	15	24	24.51	95.4	7.5432	61.7467
2025	4	26	9	25	24	25.2	95	7.5493	63.5717
2025	4	26	9	35	24	26.01	97.3	7.5432	65.2895
2025	4	26	9	45	24	24.96	98.3	7.5493	62.5586
2025	4	26	9	55	24	25.03	95.7	7.5554	63.1183
2025	4	26	10	5	24	26.22	97.5	7.5554	65.9066
2025	4	26	10	15	24	25.37	94.3	7.5554	64.1322
2025	4	26	10	25	24	24.68	98.6	7.5432	61.7466
2025	4	26	10	35	24	25.39	97	7.5554	63.8788
2025	4	26	10	45	24	26.13	95.7	7.5554	65.9066
2025	4	26	10	55	24	25.13	97.8	7.5554	63.1182
2025	4	26	11	5	24	25.45	96.3	7.5615	64.1862
2025	4	26	11	15	24	24.67	96.8	7.5493	62.0518
2025	4	26	11	25	24	25.11	95.5	7.5554	63.3716
2025	4	26	11	35	24	24.51	97.5	7.5676	61.7011
2025	4	26	11	45	24	25.46	98.1	7.5554	63.8786
2025	4	26	11	55	24	24.74	93.2	7.5493	62.5584
2025	4	26	12	5	24	24.52	95.6	7.5493	61.7986
2025	4	26	12	15	24	25.75	96.2	7.5615	64.9473
2025	4	26	12	25	24	25.68	98.5	7.5493	64.3314
2025	4	26	12	35	24	24.96	96.4	7.5615	62.9178
2025	4	26	12	45	24	25.65	98.1	7.5554	64.3857
2025	4	26	12	55	24	24.43	95.9	7.5554	61.5973
2025	4	26	13	5	24	25.73	97.6	7.5554	64.6391
2025	4	26	13	15	24	24.64	96.1	7.5615	62.1566
2025	4	26	13	25	24	24.68	97	7.5493	62.0518
2025	4	26	13	35	24	24.15	96.4	7.5554	60.8368
2025	4	26	13	45	24	24.66	96.5	7.5676	62.209
2025	4	26	13	55	24	25.01	95.3	7.5737	63.2778
2025	4	26	14	5	24	25.59	97	7.5615	64.4399
2025	4	26	14	15	24	24.76	98.4	7.5554	62.1042
2025	4	26	14	25	24	25.53	95.8	7.5615	64.4399
2025	4	26	14	35	24	26.02	95.5	7.5554	65.653

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	26	14	45	24	24.2	97.4	7.5615	60.8881
2025	4	26	14	55	24	25.28	96.8	7.5615	63.6788
2025	4	26	15	5	24	25.05	98	7.5615	62.9177
2025	4	26	15	15	24	25.42	95.6	7.5737	64.2943
2025	4	26	15	25	24	25.78	96.7	7.5676	65.0021
2025	4	26	15	35	24	24.9	95.1	7.5615	62.9178
2025	4	26	15	45	24	25.49	97	7.5615	64.1863
2025	4	26	15	55	24	25.33	95.9	7.5615	63.9326
2025	4	26	16	5	24	24.64	99.6	7.5615	61.6494
2025	4	26	16	15	24	25.37	96.6	7.5615	63.9327
2025	4	26	16	25	24	24.24	98.1	7.5676	60.9396
2025	4	26	16	35	24	24.94	96	7.5615	62.918
2025	4	26	16	45	24	25.09	97.1	7.5676	63.2249
2025	4	26	16	55	24	24.57	96.8	7.5615	61.9032
2025	4	26	17	5	24	26.76	96.2	7.5554	67.4278
2025	4	26	17	15	24	25.37	96.6	7.5554	63.879
2025	4	26	17	25	24	25.64	96	7.5554	64.6395
2025	4	26	17	35	24	24.98	96.9	7.5615	62.9181
2025	4	26	17	45	24	25.82	95.6	7.5554	65.1466
2025	4	26	17	55	24	25.13	95.9	7.5554	63.3722
2025	4	26	18	5	24	25.73	95.8	7.5554	64.8932
2025	4	26	18	15	24	24.95	98.1	7.5615	62.6646
2025	4	26	18	25	24	25.66	93.8	7.5615	64.948
2025	4	26	18	35	24	26.16	96.4	7.5554	65.9072
2025	4	26	18	45	24	26.61	95.2	7.5615	67.2314
2025	4	26	18	55	24	26.36	98.1	7.5676	66.2724
2025	4	26	19	5	24	25.99	96.9	7.5676	65.5107
2025	4	26	19	15	24	25.68	96.7	7.5676	64.7489
2025	4	26	19	25	24	25.73	97.6	7.5676	64.749
2025	4	26	19	35	24	27.38	96.5	7.5737	69.1237
2025	4	26	19	45	24	25.34	96.1	7.5676	63.9873
2025	4	26	19	55	24	25.74	97.8	7.5676	64.7491
2025	4	26	20	5	24	26.89	94.7	7.5676	68.0501
2025	4	26	20	15	24	26.07	96.6	7.5676	65.7649
2025	4	26	20	25	24	26.48	96.7	7.5676	66.7806
2025	4	26	20	35	24	27	97	7.5676	68.0502
2025	4	26	20	45	24	26.33	95.7	7.5676	66.5267
2025	4	26	20	55	24	28.5	96.9	7.5676	71.8591
2025	4	26	21	5	24	26.56	93.9	7.5676	67.2886
2025	4	26	21	15	24	26.28	96.8	7.5676	66.2729
2025	4	26	21	25	24	26.47	94.1	7.5676	67.0347
2025	4	26	21	35	24	26.95	96	7.5676	68.0504
2025	4	26	21	45	24	27.19	94.6	7.5676	68.8122
2025	4	26	21	55	24	26.59	96.9	7.5676	67.0348
2025	4	26	22	5	24	26.32	97.4	7.5676	66.2731
2025	4	26	22	15	24	26.42	95.4	7.5676	66.781
2025	4	26	22	25	24	25.9	97.1	7.5676	65.2575
2025	4	26	22	35	24	26.36	96.3	7.5676	66.5271

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	26	22	45	24	26.43	95.6	7.5676	66.781
2025	4	26	22	55	24	26.31	97.2	7.5676	66.2732
2025	4	26	23	5	24	26.21	97.2	7.5676	66.0193
2025	4	26	23	15	24	27.46	96.3	7.5676	69.3203
2025	4	26	23	25	24	26.35	97.9	7.5676	66.2733
2025	4	26	23	35	24	25.39	97	7.5676	63.988
2025	4	26	23	45	24	26.69	96.9	7.5676	67.289
2025	4	26	23	55	24	26.04	96	7.5615	65.7102
2025	4	27	0	5	24	25.47	94.3	7.5676	64.4959
2025	4	27	0	15	24	25.97	94.2	7.5676	65.7656
2025	4	27	0	25	24	25.79	96.9	7.5676	65.0038
2025	4	27	0	35	24	26.27	96.6	7.5676	66.2734
2025	4	27	0	45	24	26.23	97.7	7.5676	66.0195
2025	4	27	0	55	24	26.57	98.2	7.5676	66.7813
2025	4	27	1	5	24	25.86	96.4	7.5676	65.2578
2025	4	27	1	15	24	26.65	96	7.5676	67.2892
2025	4	27	1	25	24	25.7	95.1	7.5676	65.0039
2025	4	27	1	35	24	25.47	98.4	7.5615	63.9344
2025	4	27	1	45	24	25.58	96.7	7.5676	64.4961
2025	4	27	1	55	24	26.28	96.8	7.5615	66.2178
2025	4	27	2	5	24	25.65	96.3	7.5615	64.6956
2025	4	27	2	15	24	26.21	97.2	7.5676	66.0197
2025	4	27	2	25	24	26.75	99.3	7.5615	66.979
2025	4	27	2	35	24	26.63	95.6	7.5615	67.2327
2025	4	27	2	45	24	27.19	96.8	7.5615	68.5013
2025	4	27	2	55	24	26.57	98.2	7.5615	66.7253
2025	4	27	3	5	24	25.9	95.1	7.5615	65.4568
2025	4	27	3	15	24	25.7	97.2	7.5615	64.6957
2025	4	27	3	25	24	26.27	96.6	7.5615	66.218
2025	4	27	3	35	24	27	97	7.5615	67.9939
2025	4	27	3	45	24	26.46	93.9	7.5615	66.9791
2025	4	27	3	55	24	26.59	96.9	7.5615	66.9791
2025	4	27	4	5	24	26.59	94.7	7.5615	67.2328
2025	4	27	4	15	24	27.11	97.2	7.5615	68.2477
2025	4	27	4	25	24	26.61	97.1	7.5615	66.9792
2025	4	27	4	35	24	26.55	97.8	7.5615	66.7255
2025	4	27	4	45	24	26.5	95	7.5615	66.9792
2025	4	27	4	55	24	26.25	96.1	7.5615	66.2181
2025	4	27	5	5	24	26.51	97.2	7.5615	66.7255
2025	4	27	5	15	24	26.07	96.6	7.5615	65.7107
2025	4	27	5	25	24	26.31	97.2	7.5615	66.2181
2025	4	27	5	35	24	25.6	97.2	7.5615	64.4422
2025	4	27	5	45	24	26.56	96.3	7.5615	66.9793
2025	4	27	5	55	24	25.86	96.4	7.5615	65.2033
2025	4	27	6	5	24	26.18	94.6	7.5615	66.2182
2025	4	27	6	15	24	26.04	96	7.5615	65.7108
2025	4	27	6	25	24	25.93	95.8	7.5615	65.4571
2025	4	27	6	35	24	26.16	96.4	7.5615	65.9645

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	27	6	45	24	26.2	95	7.5615	66.2182
2025	4	27	6	55	24	25.58	98.5	7.5615	64.1885
2025	4	27	7	5	24	26.32	97.4	7.5615	66.2182
2025	4	27	7	15	24	26.14	97.7	7.5615	65.7108
2025	4	27	7	25	24	25.87	96.7	7.5615	65.2034
2025	4	27	7	35	24	26.52	97.4	7.5615	66.7256
2025	4	27	7	45	24	26.23	95.7	7.5615	66.2182
2025	4	27	7	55	24	25.65	98.1	7.5615	64.4422
2025	4	27	8	5	24	25.08	96.9	7.5615	63.1737
2025	4	27	8	15	24	24.84	96	7.5615	62.6662
2025	4	27	8	25	24	24.29	97.1	7.5615	61.1439
2025	4	27	8	35	24	26.53	95.6	7.5615	66.9792
2025	4	27	8	45	24	25.87	96.7	7.5615	65.2032
2025	4	27	8	55	24	24.81	97.4	7.5615	62.4124
2025	4	27	9	5	24	25.71	97.4	7.5615	64.6958
2025	4	27	9	15	24	25.93	95.8	7.5615	65.4569
2025	4	27	9	25	24	26.06	96.4	7.5676	65.7659
2025	4	27	9	35	24	26.31	98.7	7.5676	66.0198
2025	4	27	9	45	24	25.58	98.5	7.5676	64.2423
2025	4	27	9	55	24	26.39	97	7.5676	66.5275
2025	4	27	10	5	24	25.62	95.6	7.5676	64.75
2025	4	27	10	15	24	26.64	95.8	7.5676	67.2892
2025	4	27	10	25	24	25.89	94.7	7.5676	65.5117
2025	4	27	10	35	24	26.26	98.1	7.5676	66.0195
2025	4	27	10	45	24	26.66	98	7.5676	67.0352
2025	4	27	10	55	24	25.86	94	7.5676	65.5116
2025	4	27	11	5	24	27.27	98	7.5676	68.5586
2025	4	27	11	15	24	26.84	97.7	7.5676	67.5429
2025	4	27	11	25	24	26.77	96.4	7.5676	67.5428
2025	4	27	11	35	24	25.36	96.3	7.5676	63.9879
2025	4	27	11	45	24	25.65	96.3	7.5676	64.7496
2025	4	27	11	55	24	25.48	96.8	7.5676	64.2417
2025	4	27	12	5	24	26.72	97.3	7.5676	67.2887
2025	4	27	12	15	24	25.6	98.8	7.5676	64.2416
2025	4	27	12	25	24	26.83	95.6	7.5676	67.7965
2025	4	27	12	35	24	26	97.1	7.5676	65.5111
2025	4	27	12	45	24	25.1	95	7.5676	63.4797
2025	4	27	12	55	24	26.77	96.4	7.5676	67.5424
2025	4	27	13	5	24	26.16	98.1	7.5615	65.7096
2025	4	27	13	15	24	25.26	94.1	7.5676	63.9875
2025	4	27	13	25	24	26.57	96.5	7.5676	67.0344
2025	4	27	13	35	24	26.16	98.1	7.5615	65.7095
2025	4	27	13	45	24	24.95	96.2	7.5615	62.9187
2025	4	27	13	55	24	25.32	100.5	7.5615	63.1724
2025	4	27	14	5	24	25.36	96.3	7.5615	63.9334
2025	4	27	14	15	24	26.14	97.7	7.5554	65.654
2025	4	27	14	25	24	25.63	95.8	7.5615	64.6945
2025	4	27	14	35	24	25.52	95.6	7.5554	64.3865

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	27	14	45	24	26.01	98.8	7.5554	65.1469
2025	4	27	14	55	24	25.89	96.9	7.5554	65.1469
2025	4	27	15	5	24	25.89	96.9	7.5493	65.092
2025	4	27	15	15	24	26.58	96.7	7.5493	66.8649
2025	4	27	15	25	24	24.92	95.5	7.5493	62.8125
2025	4	27	15	35	24	25.24	98	7.5493	63.319
2025	4	27	15	45	24	25.94	96	7.5432	65.2901
2025	4	27	15	55	24	26.15	97.9	7.5432	65.5431
2025	4	27	16	5	24	25.91	97.3	7.5493	65.0919
2025	4	27	16	15	24	25.15	96.2	7.5432	63.2656
2025	4	27	16	25	24	25.59	97	7.5432	64.2778
2025	4	27	16	35	24	26.74	95.8	7.5432	67.3145
2025	4	27	16	45	24	25.83	95.8	7.5432	65.037
2025	4	27	16	55	24	26.14	97.7	7.5432	65.5431
2025	4	27	17	5	24	25.8	97.1	7.5432	64.7839
2025	4	27	17	15	24	26.77	96.4	7.5432	67.3145
2025	4	27	17	25	24	25.38	96.8	7.5432	63.7717
2025	4	27	17	35	24	26.9	97	7.5432	67.5676
2025	4	27	17	45	24	26.6	95	7.5432	67.0615
2025	4	27	17	55	24	25.94	97.8	7.5371	64.9821
2025	4	27	18	5	24	26.6	98.6	7.5371	66.4993
2025	4	27	18	15	24	26.03	95.7	7.5371	65.4879
2025	4	27	18	25	24	25.91	97.3	7.5432	65.0371
2025	4	27	18	35	24	26.59	98.4	7.5432	66.5555
2025	4	27	18	45	24	25.32	95.7	7.5371	63.718
2025	4	27	18	55	24	25.63	95.8	7.5371	64.4766
2025	4	27	19	5	24	26.49	96.9	7.5371	66.4994
2025	4	27	19	15	24	25.63	95.8	7.5371	64.4767
2025	4	27	19	25	24	26.68	96.7	7.5371	67.0052
2025	4	27	19	35	24	26.08	98.4	7.5371	65.2353
2025	4	27	19	45	24	26.76	96.2	7.5371	67.2581
2025	4	27	19	55	24	24.88	96.9	7.5371	62.454
2025	4	27	20	5	24	27.36	99.3	7.5371	68.2696
2025	4	27	20	15	24	26.05	97.9	7.5371	65.2354
2025	4	27	20	25	24	25.82	95.6	7.5371	64.9826
2025	4	27	20	35	24	26.34	95.9	7.531	66.1909
2025	4	27	20	45	24	25.63	97.6	7.531	64.1699
2025	4	27	20	55	24	25.44	96.1	7.531	63.9173
2025	4	27	21	5	24	25.44	96.1	7.531	63.9173
2025	4	27	21	15	24	26.84	95.8	7.531	67.4543
2025	4	27	21	25	24	25.87	96.7	7.531	64.9279
2025	4	27	21	35	24	26.1	97	7.531	65.4333
2025	4	27	21	45	24	26.69	96.9	7.531	66.9491
2025	4	27	21	55	24	25.36	96.3	7.531	63.6648
2025	4	27	22	5	24	25.04	99.4	7.531	62.4017
2025	4	27	22	15	24	25.86	96.4	7.5249	64.8732
2025	4	27	22	25	24	25.97	96.6	7.5249	65.1256
2025	4	27	22	35	24	25.45	96.3	7.5249	63.8635

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	27	22	45	24	25.44	97.9	7.5249	63.6111
2025	4	27	22	55	24	25.26	98.2	7.5249	63.1063
2025	4	27	23	5	24	25.5	98.8	7.5249	63.6112
2025	4	27	23	15	24	25.44	97.9	7.5249	63.6112
2025	4	27	23	25	24	24.89	97.2	7.5249	62.3491
2025	4	27	23	35	24	25.31	95.4	7.5249	63.6112
2025	4	27	23	45	24	24.93	95.8	7.5188	62.5485
2025	4	27	23	55	24	25.29	94.8	7.5188	63.5574
2025	4	28	0	5	24	24.55	96.3	7.5188	61.5397
2025	4	28	0	15	24	26.53	95.6	7.5249	66.6404
2025	4	28	0	25	24	24.88	96.9	7.5188	62.2964
2025	4	28	0	35	24	25.89	94.7	7.5188	65.0707
2025	4	28	0	45	24	25.74	96	7.5188	64.5663
2025	4	28	0	55	24	24.87	96.7	7.5188	62.2964
2025	4	28	1	5	24	26.18	96.8	7.5188	65.5752
2025	4	28	1	15	24	25.97	96.6	7.5188	65.0708
2025	4	28	1	25	24	25.92	97.5	7.5188	64.8186
2025	4	28	1	35	24	25.37	96.6	7.5188	63.5575
2025	4	28	1	45	24	24.62	92.1	7.5188	62.0442
2025	4	28	1	55	24	26.22	95.5	7.5188	65.8274
2025	4	28	2	5	24	25.75	98	7.5188	64.3141
2025	4	28	2	15	24	25.79	94.9	7.5188	64.8186
2025	4	28	2	25	24	26.42	97.4	7.5188	66.0796
2025	4	28	2	35	24	26.31	97.2	7.5188	65.8274
2025	4	28	2	45	24	25.81	98.9	7.5188	64.3141
2025	4	28	2	55	24	25.16	94.1	7.5188	63.3053
2025	4	28	3	5	24	25.43	97.7	7.5188	63.5575
2025	4	28	3	15	24	26.04	96	7.5188	65.323
2025	4	28	3	25	24	26.63	95.6	7.5188	66.8362
2025	4	28	3	35	24	25.33	95.9	7.5188	63.5575
2025	4	28	3	45	24	25.81	95.3	7.5188	64.8185
2025	4	28	3	55	24	26.61	95.2	7.5188	66.8362
2025	4	28	4	5	24	26.58	94.3	7.5188	66.8362
2025	4	28	4	15	24	25.14	93.2	7.5188	63.3052
2025	4	28	4	25	24	26.36	93.9	7.5188	66.3317
2025	4	28	4	35	24	26.25	96.1	7.5188	65.8273
2025	4	28	4	45	24	25.27	96.6	7.5188	63.3051
2025	4	28	4	55	24	26.1	95.1	7.5188	65.575
2025	4	28	5	5	24	26.45	96.1	7.5127	66.2754
2025	4	28	5	15	24	25.78	94.4	7.5188	64.8183
2025	4	28	5	25	24	25.38	96.8	7.5188	63.5573
2025	4	28	5	35	24	26.54	95.8	7.5188	66.5838
2025	4	28	5	45	24	25.14	93.2	7.5188	63.305
2025	4	28	5	55	24	25.86	96.4	7.5188	64.8183
2025	4	28	6	5	24	25.58	94.5	7.5188	64.3138
2025	4	28	6	15	24	26.8	97.1	7.5188	67.0882
2025	4	28	6	25	24	26.65	96	7.5188	66.8359
2025	4	28	6	35	24	25.13	97.8	7.5188	62.8005

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	28	6	45	24	24.94	96	7.5188	62.5483
2025	4	28	6	55	24	25.23	95.9	7.5188	63.3049
2025	4	28	7	5	24	26.47	96.5	7.5188	66.3315
2025	4	28	7	15	24	24.46	94	7.5188	61.5394
2025	4	28	7	25	24	23.64	93.4	7.5188	59.5217
2025	4	28	7	35	24	25.41	95.4	7.5188	63.8093
2025	4	28	7	45	24	26.23	97.7	7.5188	65.5747
2025	4	28	7	55	24	25.24	96.1	7.5188	63.3048
2025	4	28	8	5	24	25.13	95.9	7.5188	63.0526
2025	4	28	8	15	24	24.95	96.2	7.5188	62.5481
2025	4	28	8	25	24	24.96	93.9	7.5188	62.8003
2025	4	28	8	35	24	26.03	95.7	7.5188	65.3223
2025	4	28	8	45	24	24.99	97.1	7.5188	62.548
2025	4	28	8	55	24	25.56	94	7.5188	64.3134
2025	4	28	9	5	24	25.47	94.3	7.5188	64.0611
2025	4	28	9	15	24	25.87	96.7	7.5249	64.8726
2025	4	28	9	25	24	25.24	96.1	7.5249	63.3581
2025	4	28	9	35	24	24.92	95.5	7.5249	62.6008
2025	4	28	9	45	24	25.58	94.5	7.5249	64.3677
2025	4	28	9	55	24	27.06	96.2	7.5249	67.9015
2025	4	28	10	5	24	25.66	96.5	7.5249	64.3676
2025	4	28	10	15	24	25.8	95.1	7.5249	64.8724
2025	4	28	10	25	24	26.77	98.2	7.5249	66.8917
2025	4	28	10	35	24	27.44	97.5	7.531	68.7167
2025	4	28	10	45	24	25.89	94.7	7.531	65.1797
2025	4	28	10	55	24	24.75	93.7	7.531	62.4007
2025	4	28	11	5	24	25.89	96.9	7.531	64.927
2025	4	28	11	15	24	26.79	96.9	7.531	67.2006
2025	4	28	11	25	24	25.64	96	7.531	64.4216
2025	4	28	11	35	24	26.83	97.5	7.531	67.2005
2025	4	28	11	45	24	26.67	98.2	7.531	66.6952
2025	4	28	11	55	24	25.51	97.4	7.531	63.9162
2025	4	28	12	5	24	26.43	95.6	7.531	66.4425
2025	4	28	12	15	24	25.43	95.9	7.531	63.9161
2025	4	28	12	25	24	25.48	96.8	7.531	63.916
2025	4	28	12	35	24	25.57	96.5	7.5371	64.2229
2025	4	28	12	45	24	25.59	97	7.531	64.1686
2025	4	28	12	55	24	25.06	96.4	7.5371	62.9586
2025	4	28	13	5	24	25.08	94.6	7.5371	63.2114
2025	4	28	13	15	24	26.06	96.4	7.5371	65.487
2025	4	28	13	25	24	25.31	95.4	7.5371	63.717
2025	4	28	13	35	24	25.77	94.2	7.5371	64.9812
2025	4	28	13	45	24	26.48	96.7	7.5371	66.4982
2025	4	28	13	55	24	25.21	95.2	7.5371	63.4641
2025	4	28	14	5	24	25.47	94.3	7.5371	64.2227
2025	4	28	14	15	24	25.69	94.9	7.5371	64.7284
2025	4	28	14	25	24	25.29	97	7.5371	63.4641
2025	4	28	14	35	24	26.14	95.9	7.5371	65.7397

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	28	14	45	24	25.9	97.1	7.5371	64.9811
2025	4	28	14	55	24	25.75	96.2	7.5371	64.7283
2025	4	28	15	5	24	24.79	97.2	7.5371	62.1999
2025	4	28	15	15	24	25.38	94.5	7.5371	63.9698
2025	4	28	15	25	24	25.8	95.1	7.5371	64.9811
2025	4	28	15	35	24	25.15	96.2	7.5371	63.2112
2025	4	28	15	45	24	26.44	95.9	7.5371	66.4982
2025	4	28	15	55	24	26.07	96.6	7.5371	65.4868
2025	4	28	16	5	24	25.58	96.7	7.5371	64.2226
2025	4	28	16	15	24	26.59	94.7	7.5371	67.0039
2025	4	28	16	25	24	25.31	95.4	7.5371	63.7169
2025	4	28	16	35	24	25.23	97.7	7.5371	63.2113
2025	4	28	16	45	24	26.14	95.9	7.5371	65.7397
2025	4	28	16	55	24	25.18	94.6	7.5371	63.4641
2025	4	28	17	5	24	26.04	97.7	7.5371	65.2341
2025	4	28	17	15	24	24.82	97.6	7.5371	62.2
2025	4	28	17	25	24	25.48	94.5	7.5371	64.2228
2025	4	28	17	35	24	24.98	94.6	7.5371	62.9586
2025	4	28	17	45	24	26.09	94.8	7.5371	65.7399
2025	4	28	17	55	24	26.57	96.5	7.5371	66.7513
2025	4	28	18	5	24	24.45	96.3	7.5371	61.4416
2025	4	28	18	15	24	26.75	96	7.5371	67.2571
2025	4	28	18	25	24	26.68	94.3	7.5371	67.2571
2025	4	28	18	35	24	26.46	96.3	7.5371	66.4986
2025	4	28	18	45	24	24.08	94.5	7.5371	60.6832
2025	4	28	18	55	24	26.69	94.7	7.5371	67.2572
2025	4	28	19	5	24	25.79	94.9	7.5371	64.9816
2025	4	28	19	15	24	25.86	96.4	7.5371	64.9817
2025	4	28	19	25	24	27.18	96.5	7.5371	68.2687
2025	4	28	19	35	24	25.7	95.1	7.5371	64.7289
2025	4	28	19	45	24	26.26	93.9	7.5371	66.246
2025	4	28	19	55	24	25.47	96.5	7.5371	63.9704
2025	4	28	20	5	24	25.55	96.3	7.5371	64.2233
2025	4	28	20	15	24	26	95.1	7.5371	65.4876
2025	4	28	20	25	24	24.47	94.2	7.5371	61.6949
2025	4	28	20	35	24	25.99	96.9	7.5371	65.2349
2025	4	28	20	45	24	25.86	93.8	7.5371	65.2349
2025	4	28	20	55	24	24.94	96	7.5371	62.7065
2025	4	28	21	5	24	25.18	94.6	7.5371	63.465
2025	4	28	21	15	24	25.87	94.2	7.5371	65.235
2025	4	28	21	25	24	26.52	97.4	7.5371	66.4993
2025	4	28	21	35	24	26.1	95.1	7.5371	65.7408
2025	4	28	21	45	24	26.08	96.8	7.5371	65.488
2025	4	28	21	55	24	26.33	97.6	7.5371	65.9937
2025	4	28	22	5	24	26.98	94.5	7.5371	68.0166
2025	4	28	22	15	24	25.96	94	7.531	65.4328
2025	4	28	22	25	24	25.03	95.7	7.5371	62.9596
2025	4	28	22	35	24	26.03	95.7	7.5371	65.4882

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	28	22	45	24	25.6	97.2	7.5371	64.2239
2025	4	28	22	55	24	25.8	95.1	7.5371	64.9825
2025	4	28	23	5	24	25.98	94.6	7.5371	65.4882
2025	4	28	23	15	24	25.91	95.3	7.5371	65.2354
2025	4	28	23	25	24	25.92	95.5	7.5371	65.2355
2025	4	28	23	35	24	26.92	95.3	7.531	67.7067
2025	4	28	23	45	24	24.99	94.8	7.5371	62.9598
2025	4	28	23	55	24	26.1	95.1	7.5371	65.7412
2025	4	29	0	5	24	26.33	95.7	7.5371	66.2469
2025	4	29	0	15	24	25.57	96.5	7.5371	64.2241
2025	4	29	0	25	24	25.27	96.6	7.5371	63.4656
2025	4	29	0	35	24	24.56	96.5	7.5371	61.6956
2025	4	29	0	45	24	26.23	97.7	7.5371	65.7413
2025	4	29	0	55	24	25.44	97.9	7.5371	63.7185
2025	4	29	1	5	24	26.06	93.7	7.5371	65.7413
2025	4	29	1	15	24	25.68	96.7	7.5371	64.477
2025	4	29	1	25	24	26.38	96.7	7.5371	66.247
2025	4	29	1	35	24	25.57	96.5	7.5371	64.2242
2025	4	29	1	45	24	26.1	97	7.5371	65.4884
2025	4	29	1	55	24	26.27	99.6	7.5371	65.4884
2025	4	29	2	5	24	25.39	97	7.5371	63.7185
2025	4	29	2	15	24	26.02	99.1	7.5371	64.9827
2025	4	29	2	25	24	26.27	94.1	7.5432	66.303
2025	4	29	2	35	24	24.7	97.2	7.5371	61.9485
2025	4	29	2	45	24	25.6	95.2	7.5371	64.477
2025	4	29	2	55	24	25.59	97	7.5432	64.2784
2025	4	29	3	5	24	25.13	95.9	7.5371	63.2128
2025	4	29	3	15	24	26.7	97.1	7.5432	67.0621
2025	4	29	3	25	24	26.42	95.4	7.5432	66.556
2025	4	29	3	35	24	26.01	98.8	7.5432	65.0376
2025	4	29	3	45	24	25.98	94.6	7.5432	65.5437
2025	4	29	3	55	24	25.42	97.5	7.5371	63.7184
2025	4	29	4	5	24	25.23	93	7.5432	63.7723
2025	4	29	4	15	24	25.58	94.5	7.5432	64.5315
2025	4	29	4	25	24	26.17	94.2	7.5432	66.0499
2025	4	29	4	35	24	25.9	95.1	7.5432	65.2907
2025	4	29	4	45	24	26.01	97.3	7.5493	65.3458
2025	4	29	4	55	24	24.44	96.1	7.5493	61.5466
2025	4	29	5	5	24	26.89	96.8	7.5432	67.5683
2025	4	29	5	15	24	26.06	94	7.5432	65.7968
2025	4	29	5	25	24	24.84	96	7.5432	62.507
2025	4	29	5	35	24	25.26	93.9	7.5493	63.8261
2025	4	29	5	45	24	26.38	94.3	7.5493	66.6122
2025	4	29	5	55	24	26.83	95.6	7.5432	67.5683
2025	4	29	6	5	24	27.17	94	7.5493	68.6384
2025	4	29	6	15	24	27.15	97.8	7.5493	68.1319
2025	4	29	6	25	24	25.99	94.9	7.5554	65.6544
2025	4	29	6	35	24	25.89	94.7	7.5554	65.4009

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	29	6	45	24	25.53	97.7	7.5554	64.1334
2025	4	29	6	55	24	26.13	95.7	7.5554	65.9079
2025	4	29	7	5	24	26.38	96.7	7.5554	66.4149
2025	4	29	7	15	24	26.23	95.7	7.5615	66.2171
2025	4	29	7	25	24	25.83	95.8	7.5615	65.2023
2025	4	29	7	35	24	26.12	95.5	7.5615	65.9634
2025	4	29	7	45	24	25.99	94.9	7.5615	65.7097
2025	4	29	7	55	24	26.59	98.4	7.5554	66.6683
2025	4	29	8	5	24	26.23	95.7	7.5615	66.217
2025	4	29	8	15	24	25.53	97.7	7.5615	64.1873
2025	4	29	8	25	24	27.4	94.8	7.5615	69.2614
2025	4	29	8	35	24	26.89	94.7	7.5615	67.9928
2025	4	29	8	45	24	25.86	93.8	7.5615	65.4558
2025	4	29	8	55	24	25.24	96.1	7.5615	63.6798
2025	4	29	9	5	24	24.56	96.5	7.5554	61.8517
2025	4	29	9	15	24	26.01	95.3	7.5615	65.7093
2025	4	29	9	25	24	25.69	96.9	7.5554	64.64
2025	4	29	9	35	24	27.09	96.8	7.5554	68.1888
2025	4	29	9	45	24	25.56	93.8	7.5615	64.6944
2025	4	29	9	55	24	26.79	96.9	7.5554	67.4282
2025	4	29	10	5	24	25.61	95.4	7.5615	64.6943
2025	4	29	10	15	24	25.82	95.6	7.5676	65.2566
2025	4	29	10	25	24	25.44	96.1	7.5615	64.1868
2025	4	29	10	35	24	25.46	94.1	7.5493	64.3319
2025	4	29	10	45	24	26.9	97	7.5493	67.6244
2025	4	29	10	55	24	27.13	97.4	7.5432	68.0734
2025	4	29	11	5	24	26.28	96.8	7.5432	66.0489
2025	4	29	11	15	24	25.31	95.4	7.5432	63.7713
2025	4	29	11	25	24	25.05	96.2	7.5493	63.0653
2025	4	29	11	35	24	24.36	94	7.5493	61.5456
2025	4	29	11	45	24	26.64	95.8	7.5493	67.1176
2025	4	29	11	55	24	25.09	97.1	7.5493	63.0651
2025	4	29	12	5	24	26.52	95.4	7.5493	66.8642
2025	4	29	12	15	24	26.69	94.7	7.5493	67.3707
2025	4	29	12	25	24	27.24	99.1	7.5493	68.1304
2025	4	29	12	35	24	25.92	95.5	7.5493	65.3444
2025	4	29	12	45	24	25.29	97	7.5493	63.5714
2025	4	29	12	55	24	25.5	95.2	7.5493	64.3312
2025	4	29	13	5	24	26.72	97.3	7.5493	67.1172
2025	4	29	13	15	24	25.5	95.2	7.5493	64.3311
2025	4	29	13	25	24	26.13	95.7	7.5493	65.8507
2025	4	29	13	35	24	25.86	96.4	7.5493	65.0909
2025	4	29	13	45	24	24.91	97.4	7.5493	62.5581
2025	4	29	13	55	24	26.08	96.8	7.5493	65.5974
2025	4	29	14	5	24	25.68	96.7	7.5493	64.5843
2025	4	29	14	15	24	26.12	97.5	7.5493	65.5973
2025	4	29	14	25	24	26.12	95.5	7.5493	65.8506
2025	4	29	14	35	24	25.69	96.9	7.5493	64.5842

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	29	14	45	24	26.62	97.3	7.5493	66.8636
2025	4	29	14	55	24	25.54	96.1	7.5493	64.3309
2025	4	29	15	5	24	26.95	96	7.5493	67.8766
2025	4	29	15	15	24	26.11	98.8	7.5493	65.3439
2025	4	29	15	25	24	26.56	96.3	7.5493	66.8635
2025	4	29	15	35	24	25.86	96.4	7.5493	65.0906
2025	4	29	15	45	24	26.83	97.5	7.5493	67.3701
2025	4	29	15	55	24	25.86	96.4	7.5493	65.0906
2025	4	29	16	5	24	26.36	96.3	7.5493	66.357
2025	4	29	16	15	24	26.69	94.7	7.5493	67.3701
2025	4	29	16	25	24	26.7	97.1	7.5493	67.1168
2025	4	29	16	35	24	25.24	96.1	7.5493	63.571
2025	4	29	16	45	24	25.74	97.8	7.5493	64.5841
2025	4	29	16	55	24	26.22	95.5	7.5493	66.1037
2025	4	29	17	5	24	27.09	94.7	7.5493	68.3832
2025	4	29	17	15	24	25.73	95.8	7.5493	64.8374
2025	4	29	17	25	24	26.75	96	7.5493	67.3701
2025	4	29	17	35	24	25.36	93.8	7.5493	64.0776
2025	4	29	17	45	24	25.29	97	7.5493	63.5711
2025	4	29	17	55	24	25.72	92.5	7.5493	65.0908
2025	4	29	18	5	24	26.69	96.9	7.5493	67.117
2025	4	29	18	15	24	27.21	97.2	7.5493	68.3833
2025	4	29	18	25	24	25.99	94.9	7.5493	65.5974
2025	4	29	18	35	24	26.86	96.2	7.5493	67.6236
2025	4	29	18	45	24	26.49	98.5	7.5493	66.3573
2025	4	29	18	55	24	25.53	95.8	7.5493	64.3311
2025	4	29	19	5	24	26.9	98.6	7.5493	67.3704
2025	4	29	19	15	24	25.5	95	7.5493	64.3312
2025	4	29	19	25	24	24.65	96.3	7.5493	62.0518
2025	4	29	19	35	24	27	94.9	7.5493	68.1303
2025	4	29	19	45	24	26.45	93.7	7.5493	66.864
2025	4	29	19	55	24	26.86	93.8	7.5493	67.8772
2025	4	29	20	5	24	26.36	96.3	7.5493	66.3576
2025	4	29	20	15	24	26.04	97.7	7.5493	65.3445
2025	4	29	20	25	24	26.63	95.6	7.5493	67.1175
2025	4	29	20	35	24	26.38	96.7	7.5493	66.3577
2025	4	29	20	45	24	27.65	99.2	7.5554	69.2021
2025	4	29	20	55	24	26.75	96	7.5554	67.4277
2025	4	29	21	5	24	26.53	97.6	7.5493	66.6111
2025	4	29	21	15	24	25.31	95.4	7.5554	63.879
2025	4	29	21	25	24	27.17	96.3	7.5554	68.4418
2025	4	29	21	35	24	27.17	98	7.5615	68.2458
2025	4	29	21	45	24	27.23	97.4	7.5615	68.4996
2025	4	29	21	55	24	26.35	97.9	7.5676	66.2721
2025	4	29	22	5	24	26.43	97.6	7.5676	66.526
2025	4	29	22	15	24	26.66	96.2	7.5737	67.3444
2025	4	29	22	25	24	26.23	97.7	7.5737	66.0738
2025	4	29	22	35	24	25.36	96.3	7.5737	64.0408

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	29	22	45	24	26.45	97.8	7.5798	66.6381
2025	4	29	22	55	24	25.84	97.8	7.5798	65.1121
2025	4	29	23	5	24	26.76	97.9	7.5798	67.4012
2025	4	29	23	15	24	26.56	98	7.5798	66.8925
2025	4	29	23	25	24	27.62	97.3	7.5798	69.6903
2025	4	29	23	35	24	25.73	95.8	7.5798	65.1121
2025	4	29	23	45	24	25.99	96.9	7.5798	65.6208
2025	4	29	23	55	24	25.66	96.5	7.5798	64.8578
2025	4	30	0	5	24	25.82	97.6	7.5798	65.1122
2025	4	30	0	15	24	25.41	95.4	7.5798	64.3491
2025	4	30	0	25	24	25.91	97.3	7.5798	65.3665
2025	4	30	0	35	24	27.46	96.3	7.5798	69.4361
2025	4	30	0	45	24	26.07	96.6	7.5798	65.8752
2025	4	30	0	55	24	26.53	95.6	7.5798	67.147
2025	4	30	1	5	24	25.5	95	7.5798	64.6035
2025	4	30	1	15	24	26.95	93.6	7.5798	68.4187
2025	4	30	1	25	24	26.97	96.4	7.5798	68.1643
2025	4	30	1	35	24	26.41	97.2	7.5798	66.6383
2025	4	30	1	45	24	26.23	95.7	7.5798	66.3839
2025	4	30	1	55	24	26.37	96.5	7.5859	66.6943
2025	4	30	2	5	24	25.27	96.6	7.5859	63.8941
2025	4	30	2	15	24	26.69	94.7	7.5859	67.7125
2025	4	30	2	25	24	26.63	97.6	7.5798	67.1469
2025	4	30	2	35	24	25.52	95.6	7.5859	64.6578
2025	4	30	2	45	24	26	97.1	7.5859	65.676
2025	4	30	2	55	24	25.96	96.4	7.5798	65.6208
2025	4	30	3	5	24	26.08	96.8	7.5798	65.8752
2025	4	30	3	15	24	25.73	95.8	7.5798	65.1121
2025	4	30	3	25	24	27.13	97.4	7.5859	68.4761
2025	4	30	3	35	24	27.24	97.6	7.5798	68.6729
2025	4	30	3	45	24	26.82	97.3	7.5798	67.6555
2025	4	30	3	55	24	25.06	96.4	7.5798	63.3316
2025	4	30	4	5	24	26.05	96.2	7.5798	65.8751
2025	4	30	4	15	24	26.63	97.6	7.5798	67.1468
2025	4	30	4	25	24	27.07	96.4	7.5798	68.4185
2025	4	30	4	35	24	25.91	98.9	7.5798	65.112
2025	4	30	4	45	24	26.56	98	7.5798	66.8924
2025	4	30	4	55	24	26.24	95.9	7.5798	66.3837
2025	4	30	5	5	24	26.2	97	7.5798	66.1293
2025	4	30	5	15	24	26.77	96.4	7.5798	67.6553
2025	4	30	5	25	24	26.52	97.4	7.5798	66.8923
2025	4	30	5	35	24	27.28	98.2	7.5737	68.615
2025	4	30	5	45	24	25.92	97.5	7.5737	65.3112
2025	4	30	5	55	24	26.11	97.3	7.5737	65.8195
2025	4	30	6	5	24	26.48	96.7	7.5676	66.7798
2025	4	30	6	15	24	25.37	96.6	7.5676	63.9867
2025	4	30	6	25	24	26.53	95.6	7.5676	67.0337
2025	4	30	6	35	24	25.87	94.2	7.5615	65.455

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	30	6	45	24	25.54	97.9	7.5615	64.1865
2025	4	30	6	55	24	25.66	96.5	7.5615	64.6939
2025	4	30	7	5	24	25.79	96.9	7.5554	64.8929
2025	4	30	7	15	24	25.91	95.3	7.5554	65.3998
2025	4	30	7	25	24	25.26	98.2	7.5554	63.3719
2025	4	30	7	35	24	26.3	95	7.5554	66.4137
2025	4	30	7	45	24	26.35	96.1	7.5554	66.4137
2025	4	30	7	55	24	26.88	98.3	7.5554	67.4276
2025	4	30	8	5	24	27.3	96.9	7.5554	68.695
2025	4	30	8	15	24	26.95	99.2	7.5554	67.4275
2025	4	30	8	25	24	26.93	97.5	7.5554	67.681
2025	4	30	8	35	24	27.21	98.7	7.5554	68.1879
2025	4	30	8	45	24	26.41	95.2	7.5554	66.6669
2025	4	30	8	55	24	26.31	95.2	7.5554	66.4134
2025	4	30	9	5	24	25.75	96.2	7.5554	64.8924
2025	4	30	9	15	24	25.92	97.5	7.5554	65.1458
2025	4	30	9	25	24	26.02	95.5	7.5554	65.6528
2025	4	30	9	35	24	27.63	95.6	7.5554	69.7085
2025	4	30	9	45	24	27.03	97.4	7.5554	67.9341
2025	4	30	9	55	24	26.99	94.7	7.5554	68.1875
2025	4	30	10	5	24	26.51	95.2	7.5554	66.9201
2025	4	30	10	15	24	27.28	94.4	7.5554	68.9479
2025	4	30	10	25	24	26.57	98.2	7.5493	66.6102
2025	4	30	10	35	24	27.42	97.3	7.5554	68.9478
2025	4	30	10	45	24	25.73	95.8	7.5554	64.892
2025	4	30	10	55	24	26.53	97.6	7.5554	66.6664
2025	4	30	11	5	24	26.33	95.7	7.5554	66.4128
2025	4	30	11	15	24	26.08	96.8	7.5554	65.6524
2025	4	30	11	25	24	25.3	95	7.5554	63.8779
2025	4	30	11	35	24	26.38	96.7	7.5554	66.4127
2025	4	30	11	45	24	26.21	95.3	7.5554	66.1592
2025	4	30	11	55	24	26.06	96.4	7.5554	65.6522
2025	4	30	12	5	24	25.7	95.1	7.5554	64.8917
2025	4	30	12	15	24	27.27	96.3	7.5554	68.6939
2025	4	30	12	25	24	25.1	97.3	7.5554	63.1173
2025	4	30	12	35	24	26.78	94.5	7.5554	67.6799
2025	4	30	12	45	24	25.91	97.3	7.5554	65.145
2025	4	30	12	55	24	25.6	95.2	7.5554	64.638
2025	4	30	13	5	24	25.6	95.2	7.5554	64.6379
2025	4	30	13	15	24	26.73	97.5	7.5554	67.1726
2025	4	30	13	25	24	25.91	97.3	7.5554	65.1447
2025	4	30	13	35	24	26.1	97	7.5554	65.6517
2025	4	30	13	45	24	26.3	97	7.5554	66.1587
2025	4	30	13	55	24	26.39	94.8	7.5554	66.6657
2025	4	30	14	5	24	26.84	97.7	7.5554	67.4262
2025	4	30	14	15	24	26.4	95	7.5554	66.6658
2025	4	30	14	25	24	26.51	95.2	7.5554	66.9193
2025	4	30	14	35	24	27.14	93	7.5493	68.6358

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	30	14	45	24	25.5	95.2	7.5554	64.3844
2025	4	30	14	55	24	27.21	95.1	7.5554	68.6936
2025	4	30	15	5	24	25.59	97	7.5554	64.3844
2025	4	30	15	15	24	25.98	94.6	7.5554	65.6519
2025	4	30	15	25	24	27.03	95.5	7.5554	68.1867
2025	4	30	15	35	24	27.24	95.9	7.5493	68.6358
2025	4	30	15	45	24	26.98	96.6	7.5493	67.876
2025	4	30	15	55	24	27.71	95.2	7.5493	69.9021
2025	4	30	16	5	24	26.86	93.8	7.5493	67.876
2025	4	30	16	15	24	26.84	95.8	7.5493	67.6228
2025	4	30	16	25	24	26.29	94.8	7.5493	66.3564
2025	4	30	16	35	24	25.45	96.3	7.5493	64.077
2025	4	30	16	45	24	26.97	96.4	7.5493	67.8761
2025	4	30	16	55	24	26.49	96.9	7.5493	66.6098
2025	4	30	17	5	24	26.04	96	7.5493	65.5968
2025	4	30	17	15	24	27.5	95	7.5493	69.3958
2025	4	30	17	25	24	27.14	95.9	7.5493	68.3828
2025	4	30	17	35	24	26.23	95.7	7.5493	66.1034
2025	4	30	17	45	24	26.78	94.5	7.5493	67.623
2025	4	30	17	55	24	26.39	94.8	7.5493	66.61
2025	4	30	18	5	24	26.92	95.3	7.5493	67.8764
2025	4	30	18	15	24	26.83	95.6	7.5493	67.6231
2025	4	30	18	25	24	26.01	95.3	7.5493	65.597
2025	4	30	18	35	24	27.07	94	7.5432	68.3253
2025	4	30	18	45	24	27.06	93.8	7.5432	68.3254
2025	4	30	18	55	24	27.7	94.8	7.5432	69.8438
2025	4	30	19	5	24	26.16	93.7	7.5432	66.048
2025	4	30	19	15	24	27.01	95.1	7.5432	68.0724
2025	4	30	19	25	24	26.81	95.1	7.5432	67.5664
2025	4	30	19	35	24	26.47	94.1	7.5432	66.8073
2025	4	30	19	45	24	27.88	94.3	7.5432	70.3501
2025	4	30	19	55	24	25.57	96.5	7.5432	64.2768
2025	4	30	20	5	24	26.48	94.5	7.5432	66.8074
2025	4	30	20	15	24	26.52	97.4	7.5432	66.5544
2025	4	30	20	25	24	26.57	96.5	7.5432	66.8075
2025	4	30	20	35	24	26.29	94.8	7.5371	66.2454
2025	4	30	20	45	24	26.75	96	7.5432	67.3136
2025	4	30	20	55	24	25.86	94	7.5371	65.2341
2025	4	30	21	5	24	28.22	95.3	7.5371	71.0496
2025	4	30	21	15	24	27.22	95.3	7.5371	68.5211
2025	4	30	21	25	24	26.83	95.6	7.5371	67.5098
2025	4	30	21	35	24	27.32	95.5	7.5371	68.7741
2025	4	30	21	45	24	26.11	95.3	7.5371	65.7399
2025	4	30	21	55	24	26.93	95.5	7.5371	67.7627
2025	4	30	22	5	24	26.13	95.7	7.5371	65.74
2025	4	30	22	15	24	26	95.1	7.5371	65.4872
2025	4	30	22	25	24	26.31	97.2	7.5371	65.9929
2025	4	30	22	35	24	26.66	96.2	7.5371	67.0043

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	4	30	22	45	24	24.03	92.6	7.5371	60.6831
2025	4	30	22	55	24	25.93	95.8	7.5371	65.2344
2025	4	30	23	5	24	26.38	96.7	7.5371	66.2458
2025	4	30	23	15	24	25.37	96.6	7.5371	63.7173
2025	4	30	23	25	24	27.05	95.9	7.5371	68.0157
2025	4	30	23	35	24	27.42	98.8	7.5371	68.5214
2025	4	30	23	45	24	26.78	96.6	7.5371	67.2572
2025	4	30	23	55	24	24.98	96.9	7.5371	62.706

Alabama Gates Release

Station 0087

Date	Flow (cfs)
4/1/2025	0.00
4/2/2025	0.00
4/3/2025	0.00
4/4/2025	0.00
4/5/2025	0.00
4/6/2025	0.00
4/7/2025	0.00
4/8/2025	0.00
4/9/2025	0.00
4/10/2025	0.00
4/11/2025	0.00
4/12/2025	0.00
4/13/2025	0.00
4/14/2025	0.00
4/15/2025	0.00
4/16/2025	0.00
4/17/2025	0.00
4/18/2025	0.00
4/19/2025	0.00
4/20/2025	0.00
4/21/2025	0.00
4/22/2025	0.00
4/23/2025	0.00
4/24/2025	0.00
4/25/2025	0.00
4/26/2025	0.00
4/27/2025	0.00
4/28/2025	0.00
4/29/2025	0.00
4/30/2025	0.00

Langemann Gate to Delta Weir to Delta Pumpback Station Discharge

DATE	FLOW (CFS)	FLOW (CFS)	FLOW (CFS)
4/1/2025	12	0	36
4/2/2025	13	0	34
4/3/2025	13	0	35
4/4/2025	13	0	35
4/5/2025	13	0	34
4/6/2025	13	0	34
4/7/2025	13	0	34
4/8/2025	13	0	35
4/9/2025	13	0	38
4/10/2025	13	0	38
4/11/2025	13	0	37
4/12/2025	13	0	36
4/13/2025	13	0	36
4/14/2025	13	0	36
4/15/2025	13	0	39
4/16/2025	13	0	41
4/17/2025	13	0	43
4/18/2025	13	0	44
4/19/2025	13	0	43
4/20/2025	13	0	43
4/21/2025	13	0	42
4/22/2025	13	0	43
4/23/2025	13	0	44
4/24/2025	13	0	44
4/25/2025	13	0	44
4/26/2025	13	0	44
4/27/2025	13	0	44
4/28/2025	13	0	44
4/29/2025	13	0	44
4/30/2025	13	0	44

Pumpback Station Discharge (0364)

4/1/25 0:00 == 33.2	4/1/25 4:30 == 33.4	4/1/25 9:00 == 33.1	4/1/25 13:30 == 34.1
4/1/25 0:05 == 33.2	4/1/25 4:35 == 33.3	4/1/25 9:05 == 33.2	4/1/25 13:35 == 33.9
4/1/25 0:10 == 33.4	4/1/25 4:40 == 33.3	4/1/25 9:10 == 33.4	4/1/25 13:40 == 34
4/1/25 0:15 == 33.2	4/1/25 4:45 == 33.3	4/1/25 9:15 == 33.3	4/1/25 13:45 == 34
4/1/25 0:20 == 46.2	4/1/25 4:50 == 33.4	4/1/25 9:20 == 33.3	4/1/25 13:50 == 33.9
4/1/25 0:25 == 48.1	4/1/25 4:55 == 33.3	4/1/25 9:25 == 33.3	4/1/25 13:55 == 34
4/1/25 0:30 == 48.1	4/1/25 5:00 == 33.3	4/1/25 9:30 == 33.3	4/1/25 14:00 == 34
4/1/25 0:35 == 48.1	4/1/25 5:05 == 33.4	4/1/25 9:35 == 33.4	4/1/25 14:05 == 33.9
4/1/25 0:40 == 48.1	4/1/25 5:10 == 33.5	4/1/25 9:40 == 33.4	4/1/25 14:10 == 33.9
4/1/25 0:45 == 47.9	4/1/25 5:15 == 33.3	4/1/25 9:45 == 33.4	4/1/25 14:15 == 33.9
4/1/25 0:50 == 47.9	4/1/25 5:20 == 33.3	4/1/25 9:50 == 33.4	4/1/25 14:20 == 34
4/1/25 0:55 == 47.9	4/1/25 5:25 == 33.3	4/1/25 9:55 == 33.5	4/1/25 14:25 == 33.9
4/1/25 1:00 == 43.8	4/1/25 5:30 == 33.3	4/1/25 10:00 == 33.4	4/1/25 14:30 == 33.7
4/1/25 1:05 == 36.1	4/1/25 5:35 == 33.2	4/1/25 10:05 == 33.6	4/1/25 14:35 == 33.5
4/1/25 1:10 == 33.2	4/1/25 5:40 == 33.4	4/1/25 10:10 == 33.5	4/1/25 14:40 == 33.7
4/1/25 1:15 == 33.2	4/1/25 5:45 == 33.3	4/1/25 10:15 == 33.4	4/1/25 14:45 == 33.7
4/1/25 1:20 == 33.3	4/1/25 5:50 == 33.3	4/1/25 10:20 == 33.4	4/1/25 14:50 == 33.6
4/1/25 1:25 == 33.4	4/1/25 5:55 == 33.4	4/1/25 10:25 == 33.4	4/1/25 14:55 == 33.8
4/1/25 1:30 == 33.3	4/1/25 6:00 == 33.4	4/1/25 10:30 == 33.5	4/1/25 15:00 == 33.8
4/1/25 1:35 == 33.2	4/1/25 6:05 == 33.5	4/1/25 10:35 == 33.5	4/1/25 15:05 == 33.8
4/1/25 1:40 == 33.3	4/1/25 6:10 == 33.4	4/1/25 10:40 == 33.7	4/1/25 15:10 == 34
4/1/25 1:45 == 33.3	4/1/25 6:15 == 35.2	4/1/25 10:45 == 33.6	4/1/25 15:15 == 33.7
4/1/25 1:50 == 33.4	4/1/25 6:20 == 43.5	4/1/25 10:50 == 33.7	4/1/25 15:20 == 33.7
4/1/25 1:55 == 33.5	4/1/25 6:25 == 47.8	4/1/25 10:55 == 33.6	4/1/25 15:25 == 33.9
4/1/25 2:00 == 33.5	4/1/25 6:30 == 48.2	4/1/25 11:00 == 33.6	4/1/25 15:30 == 33.8
4/1/25 2:05 == 33.4	4/1/25 6:35 == 48.2	4/1/25 11:05 == 33.8	4/1/25 15:35 == 34
4/1/25 2:10 == 33.4	4/1/25 6:40 == 48.1	4/1/25 11:10 == 33.8	4/1/25 15:40 == 33.9
4/1/25 2:15 == 33.5	4/1/25 6:45 == 43.9	4/1/25 11:15 == 33.7	4/1/25 15:45 == 33.7
4/1/25 2:20 == 33.5	4/1/25 6:50 == 36.9	4/1/25 11:20 == 33.7	4/1/25 15:50 == 33.8
4/1/25 2:25 == 33.6	4/1/25 6:55 == 33.6	4/1/25 11:25 == 33.8	4/1/25 15:55 == 33.8
4/1/25 2:30 == 33.5	4/1/25 7:00 == 33.6	4/1/25 11:30 == 33.7	4/1/25 16:00 == 34
4/1/25 2:35 == 33.5	4/1/25 7:05 == 33.6	4/1/25 11:35 == 33.7	4/1/25 16:05 == 34.1
4/1/25 2:40 == 33.3	4/1/25 7:10 == 33.8	4/1/25 11:40 == 33.9	4/1/25 16:10 == 34.1
4/1/25 2:45 == 33.4	4/1/25 7:15 == 33.9	4/1/25 11:45 == 33.8	4/1/25 16:15 == 33.8
4/1/25 2:50 == 33.4	4/1/25 7:20 == 34	4/1/25 11:50 == 33.8	4/1/25 16:20 == 34
4/1/25 2:55 == 33.4	4/1/25 7:25 == 33.8	4/1/25 11:55 == 33.5	4/1/25 16:25 == 33.9
4/1/25 3:00 == 33.2	4/1/25 7:30 == 33.7	4/1/25 12:00 == 33.3	4/1/25 16:30 == 33.8
4/1/25 3:05 == 33.3	4/1/25 7:35 == 33.7	4/1/25 12:05 == 33.5	4/1/25 16:35 == 34
4/1/25 3:10 == 33.5	4/1/25 7:40 == 33.7	4/1/25 12:10 == 33.6	4/1/25 16:40 == 34
4/1/25 3:15 == 34.6	4/1/25 7:45 == 33.6	4/1/25 12:15 == 33.7	4/1/25 16:45 == 33.8
4/1/25 3:20 == 45	4/1/25 7:50 == 33.7	4/1/25 12:20 == 33.6	4/1/25 16:50 == 33.6
4/1/25 3:25 == 47.8	4/1/25 7:55 == 33.5	4/1/25 12:25 == 33.6	4/1/25 16:55 == 33.7
4/1/25 3:30 == 48.1	4/1/25 8:00 == 33.6	4/1/25 12:30 == 33.5	4/1/25 17:00 == 33.8
4/1/25 3:35 == 47.9	4/1/25 8:05 == 33.5	4/1/25 12:35 == 33.6	4/1/25 17:05 == 33.8
4/1/25 3:40 == 48	4/1/25 8:10 == 33.3	4/1/25 12:40 == 33.6	4/1/25 17:10 == 33.8
4/1/25 3:45 == 48	4/1/25 8:15 == 33.4	4/1/25 12:45 == 33.6	4/1/25 17:15 == 33.9
4/1/25 3:50 == 47.9	4/1/25 8:20 == 33.2	4/1/25 12:50 == 33.5	4/1/25 17:20 == 34
4/1/25 3:55 == 48.1	4/1/25 8:25 == 33.2	4/1/25 12:55 == 33.6	4/1/25 17:25 == 33.9
4/1/25 4:00 == 43.7	4/1/25 8:30 == 33.2	4/1/25 13:00 == 33.7	4/1/25 17:30 == 33.8
4/1/25 4:05 == 36.6	4/1/25 8:35 == 33.2	4/1/25 13:05 == 33.6	4/1/25 17:35 == 33.9
4/1/25 4:10 == 33.4	4/1/25 8:40 == 33.3	4/1/25 13:10 == 33.7	4/1/25 17:40 == 34.1
4/1/25 4:15 == 33.4	4/1/25 8:45 == 33.2	4/1/25 13:15 == 33.8	4/1/25 17:45 == 34.1
4/1/25 4:20 == 33.3	4/1/25 8:50 == 33.3	4/1/25 13:20 == 33.6	4/1/25 17:50 == 34.1
4/1/25 4:25 == 33.3	4/1/25 8:55 == 33.3	4/1/25 13:25 == 34	4/1/25 17:55 == 34.1

Pumpback Station Discharge (0364)

4/1/25 18:00 == 33.8	4/1/25 22:30 == 35.3	4/2/25 3:00 == 33.6	4/2/25 7:30 == 34
4/1/25 18:05 == 34.1	4/1/25 22:35 == 41.2	4/2/25 3:05 == 33.4	4/2/25 7:35 == 34
4/1/25 18:10 == 34.1	4/1/25 22:40 == 47.4	4/2/25 3:10 == 33.5	4/2/25 7:40 == 33.9
4/1/25 18:15 == 33.9	4/1/25 22:45 == 47.3	4/2/25 3:15 == 33.6	4/2/25 7:45 == 33.8
4/1/25 18:20 == 34	4/1/25 22:50 == 48.1	4/2/25 3:20 == 33.6	4/2/25 7:50 == 34
4/1/25 18:25 == 34.1	4/1/25 22:55 == 48	4/2/25 3:25 == 33.6	4/2/25 7:55 == 33.9
4/1/25 18:30 == 34	4/1/25 23:00 == 46.3	4/2/25 3:30 == 33.6	4/2/25 8:00 == 33.9
4/1/25 18:35 == 33.9	4/1/25 23:05 == 37.8	4/2/25 3:35 == 33.6	4/2/25 8:05 == 33.8
4/1/25 18:40 == 34	4/1/25 23:10 == 34	4/2/25 3:40 == 33.6	4/2/25 8:10 == 33.5
4/1/25 18:45 == 33.9	4/1/25 23:15 == 33.9	4/2/25 3:45 == 33.6	4/2/25 8:15 == 33.3
4/1/25 18:50 == 33.8	4/1/25 23:20 == 34	4/2/25 3:50 == 33.5	4/2/25 8:20 == 33.3
4/1/25 18:55 == 33.7	4/1/25 23:25 == 34	4/2/25 3:55 == 33.6	4/2/25 8:25 == 33.5
4/1/25 19:00 == 33.6	4/1/25 23:30 == 33.9	4/2/25 4:00 == 33.5	4/2/25 8:30 == 33.5
4/1/25 19:05 == 33.6	4/1/25 23:35 == 33.7	4/2/25 4:05 == 33.7	4/2/25 8:35 == 33.3
4/1/25 19:10 == 33.6	4/1/25 23:40 == 33.6	4/2/25 4:10 == 33.8	4/2/25 8:40 == 33.4
4/1/25 19:15 == 33.6	4/1/25 23:45 == 33.4	4/2/25 4:15 == 33.5	4/2/25 8:45 == 33.3
4/1/25 19:20 == 33.5	4/1/25 23:50 == 33.5	4/2/25 4:20 == 33.7	4/2/25 8:50 == 33.4
4/1/25 19:25 == 33.6	4/1/25 23:55 == 33.4	4/2/25 4:25 == 33.7	4/2/25 8:55 == 33.5
4/1/25 19:30 == 33.8	4/2/25 0:00 == 33.4	4/2/25 4:30 == 33.7	4/2/25 9:00 == 33.4
4/1/25 19:35 == 33.7	4/2/25 0:05 == 33.4	4/2/25 4:35 == 33.7	4/2/25 9:05 == 33.4
4/1/25 19:40 == 33.6	4/2/25 0:10 == 33.5	4/2/25 4:40 == 33.7	4/2/25 9:10 == 33.5
4/1/25 19:45 == 33.6	4/2/25 0:15 == 33.5	4/2/25 4:45 == 33.6	4/2/25 9:15 == 33.4
4/1/25 19:50 == 33.6	4/2/25 0:20 == 33.5	4/2/25 4:50 == 33.6	4/2/25 9:20 == 33.5
4/1/25 19:55 == 33.6	4/2/25 0:25 == 33.6	4/2/25 4:55 == 33.6	4/2/25 9:25 == 33.6
4/1/25 20:00 == 33.6	4/2/25 0:30 == 33.6	4/2/25 5:00 == 33.6	4/2/25 9:30 == 33.3
4/1/25 20:05 == 33.6	4/2/25 0:35 == 33.6	4/2/25 5:05 == 33.7	4/2/25 9:35 == 33.5
4/1/25 20:10 == 33.7	4/2/25 0:40 == 33.6	4/2/25 5:10 == 33.6	4/2/25 9:40 == 33.7
4/1/25 20:15 == 33.6	4/2/25 0:45 == 33.6	4/2/25 5:15 == 33.7	4/2/25 9:45 == 33.7
4/1/25 20:20 == 33.8	4/2/25 0:50 == 33.5	4/2/25 5:20 == 33.6	4/2/25 9:50 == 33.7
4/1/25 20:25 == 34.1	4/2/25 0:55 == 33.5	4/2/25 5:25 == 33.7	4/2/25 9:55 == 33.7
4/1/25 20:30 == 33.9	4/2/25 1:00 == 33.5	4/2/25 5:30 == 33.5	4/2/25 10:00 == 33.7
4/1/25 20:35 == 33.9	4/2/25 1:05 == 33.5	4/2/25 5:35 == 33.4	4/2/25 10:05 == 33.7
4/1/25 20:40 == 33.9	4/2/25 1:10 == 33.7	4/2/25 5:40 == 33.6	4/2/25 10:10 == 33.7
4/1/25 20:45 == 33.9	4/2/25 1:15 == 33.6	4/2/25 5:45 == 33.7	4/2/25 10:15 == 33.6
4/1/25 20:50 == 33.8	4/2/25 1:20 == 33.5	4/2/25 5:50 == 33.6	4/2/25 10:20 == 33.6
4/1/25 20:55 == 33.6	4/2/25 1:25 == 33.6	4/2/25 5:55 == 33.8	4/2/25 10:25 == 33.7
4/1/25 21:00 == 33.5	4/2/25 1:30 == 33.5	4/2/25 6:00 == 33.8	4/2/25 10:30 == 33.7
4/1/25 21:05 == 33.7	4/2/25 1:35 == 33.6	4/2/25 6:05 == 33.6	4/2/25 10:35 == 33.6
4/1/25 21:10 == 33.7	4/2/25 1:40 == 33.5	4/2/25 6:10 == 33.7	4/2/25 10:40 == 33.8
4/1/25 21:15 == 33.7	4/2/25 1:45 == 33.3	4/2/25 6:15 == 33.7	4/2/25 10:45 == 33.7
4/1/25 21:20 == 33.6	4/2/25 1:50 == 33.3	4/2/25 6:20 == 33.7	4/2/25 10:50 == 33.7
4/1/25 21:25 == 33.5	4/2/25 1:55 == 33.9	4/2/25 6:25 == 33.8	4/2/25 10:55 == 33.9
4/1/25 21:30 == 33.3	4/2/25 2:00 == 33.8	4/2/25 6:30 == 33.8	4/2/25 11:00 == 34
4/1/25 21:35 == 33.5	4/2/25 2:05 == 33.8	4/2/25 6:35 == 33.8	4/2/25 11:05 == 34
4/1/25 21:40 == 33.7	4/2/25 2:10 == 33.8	4/2/25 6:40 == 34	4/2/25 11:10 == 34
4/1/25 21:45 == 33.6	4/2/25 2:15 == 33.8	4/2/25 6:45 == 33.7	4/2/25 11:15 == 34
4/1/25 21:50 == 33.5	4/2/25 2:20 == 33.8	4/2/25 6:50 == 33.8	4/2/25 11:20 == 33.9
4/1/25 21:55 == 33.7	4/2/25 2:25 == 33.9	4/2/25 6:55 == 34.1	4/2/25 11:25 == 34
4/1/25 22:00 == 33.7	4/2/25 2:30 == 34	4/2/25 7:00 == 33.9	4/2/25 11:30 == 34.1
4/1/25 22:05 == 33.7	4/2/25 2:35 == 33.9	4/2/25 7:05 == 34	4/2/25 11:35 == 34
4/1/25 22:10 == 33.7	4/2/25 2:40 == 33.7	4/2/25 7:10 == 34.3	4/2/25 11:40 == 34
4/1/25 22:15 == 33.6	4/2/25 2:45 == 33.8	4/2/25 7:15 == 34	4/2/25 11:45 == 33.9
4/1/25 22:20 == 33.5	4/2/25 2:50 == 33.7	4/2/25 7:20 == 34.2	4/2/25 11:50 == 33.8
4/1/25 22:25 == 33.6	4/2/25 2:55 == 33.6	4/2/25 7:25 == 34.2	4/2/25 11:55 == 33.8

Pumpback Station Discharge (0364)

4/2/25 12:00 == 33.4	4/2/25 16:30 == 33.6	4/2/25 21:00 == 33.5	4/3/25 1:30 == 33.7
4/2/25 12:05 == 33.5	4/2/25 16:35 == 33.8	4/2/25 21:05 == 33.6	4/3/25 1:35 == 33.5
4/2/25 12:10 == 33.6	4/2/25 16:40 == 33.8	4/2/25 21:10 == 33.7	4/3/25 1:40 == 33.6
4/2/25 12:15 == 33.3	4/2/25 16:45 == 33.6	4/2/25 21:15 == 33.7	4/3/25 1:45 == 33.7
4/2/25 12:20 == 33.5	4/2/25 16:50 == 33.6	4/2/25 21:20 == 33.7	4/3/25 1:50 == 33.6
4/2/25 12:25 == 33.4	4/2/25 16:55 == 33.7	4/2/25 21:25 == 33.8	4/3/25 1:55 == 33.9
4/2/25 12:30 == 33.4	4/2/25 17:00 == 33.5	4/2/25 21:30 == 33.6	4/3/25 2:00 == 34
4/2/25 12:35 == 33.3	4/2/25 17:05 == 33.6	4/2/25 21:35 == 33.5	4/3/25 2:05 == 34.1
4/2/25 12:40 == 33.3	4/2/25 17:10 == 34.1	4/2/25 21:40 == 33.7	4/3/25 2:10 == 34.1
4/2/25 12:45 == 33.3	4/2/25 17:15 == 33.8	4/2/25 21:45 == 33.8	4/3/25 2:15 == 33.9
4/2/25 12:50 == 33.3	4/2/25 17:20 == 33.7	4/2/25 21:50 == 33.9	4/3/25 2:20 == 33.9
4/2/25 12:55 == 33.4	4/2/25 17:25 == 33.8	4/2/25 21:55 == 33.9	4/3/25 2:25 == 34.1
4/2/25 13:00 == 33.4	4/2/25 17:30 == 33.9	4/2/25 22:00 == 33.7	4/3/25 2:30 == 34.1
4/2/25 13:05 == 33.3	4/2/25 17:35 == 33.9	4/2/25 22:05 == 33.7	4/3/25 2:35 == 34
4/2/25 13:10 == 33.5	4/2/25 17:40 == 34.1	4/2/25 22:10 == 33.6	4/3/25 2:40 == 33.7
4/2/25 13:15 == 33.4	4/2/25 17:45 == 34.2	4/2/25 22:15 == 33.4	4/3/25 2:45 == 33.6
4/2/25 13:20 == 33.3	4/2/25 17:50 == 34	4/2/25 22:20 == 33.5	4/3/25 2:50 == 33.8
4/2/25 13:25 == 33.5	4/2/25 17:55 == 33.9	4/2/25 22:25 == 33.9	4/3/25 2:55 == 33.8
4/2/25 13:30 == 33.5	4/2/25 18:00 == 33.9	4/2/25 22:30 == 33.7	4/3/25 3:00 == 33.5
4/2/25 13:35 == 33.5	4/2/25 18:05 == 34	4/2/25 22:35 == 33.9	4/3/25 3:05 == 33.6
4/2/25 13:40 == 33.6	4/2/25 18:10 == 33.8	4/2/25 22:40 == 34.2	4/3/25 3:10 == 33.7
4/2/25 13:45 == 33.6	4/2/25 18:15 == 33.8	4/2/25 22:45 == 34.1	4/3/25 3:15 == 33.5
4/2/25 13:50 == 33.6	4/2/25 18:20 == 33.8	4/2/25 22:50 == 34	4/3/25 3:20 == 33.6
4/2/25 13:55 == 33.8	4/2/25 18:25 == 33.8	4/2/25 22:55 == 34	4/3/25 3:25 == 33.6
4/2/25 14:00 == 33.8	4/2/25 18:30 == 33.8	4/2/25 23:00 == 34	4/3/25 3:30 == 33.4
4/2/25 14:05 == 33.7	4/2/25 18:35 == 33.9	4/2/25 23:05 == 33.9	4/3/25 3:35 == 33.4
4/2/25 14:10 == 33.6	4/2/25 18:40 == 33.9	4/2/25 23:10 == 33.8	4/3/25 3:40 == 33.8
4/2/25 14:15 == 33.6	4/2/25 18:45 == 33.6	4/2/25 23:15 == 33.7	4/3/25 3:45 == 33.5
4/2/25 14:20 == 33.7	4/2/25 18:50 == 33.5	4/2/25 23:20 == 33.6	4/3/25 3:50 == 33.6
4/2/25 14:25 == 33.9	4/2/25 18:55 == 33.6	4/2/25 23:25 == 33.5	4/3/25 3:55 == 33.4
4/2/25 14:30 == 33.3	4/2/25 19:00 == 33.6	4/2/25 23:30 == 33.6	4/3/25 4:00 == 33.4
4/2/25 14:35 == 33.6	4/2/25 19:05 == 33.6	4/2/25 23:35 == 33.6	4/3/25 4:05 == 33.5
4/2/25 14:40 == 33.8	4/2/25 19:10 == 33.7	4/2/25 23:40 == 33.4	4/3/25 4:10 == 33.7
4/2/25 14:45 == 33.5	4/2/25 19:15 == 33.7	4/2/25 23:45 == 33.3	4/3/25 4:15 == 33.8
4/2/25 14:50 == 33.6	4/2/25 19:20 == 33.8	4/2/25 23:50 == 33.4	4/3/25 4:20 == 33.6
4/2/25 14:55 == 33.9	4/2/25 19:25 == 33.8	4/2/25 23:55 == 33.4	4/3/25 4:25 == 33.7
4/2/25 15:00 == 33.6	4/2/25 19:30 == 33.6	4/3/25 0:00 == 33.4	4/3/25 4:30 == 33.6
4/2/25 15:05 == 33.6	4/2/25 19:35 == 33.7	4/3/25 0:05 == 33.4	4/3/25 4:35 == 33.6
4/2/25 15:10 == 33.7	4/2/25 19:40 == 33.9	4/3/25 0:10 == 33.4	4/3/25 4:40 == 33.5
4/2/25 15:15 == 33.8	4/2/25 19:45 == 33.5	4/3/25 0:15 == 33.4	4/3/25 4:45 == 33.6
4/2/25 15:20 == 33.8	4/2/25 19:50 == 33.4	4/3/25 0:20 == 33.3	4/3/25 4:50 == 33.6
4/2/25 15:25 == 33.7	4/2/25 19:55 == 33.7	4/3/25 0:25 == 33.4	4/3/25 4:55 == 33.6
4/2/25 15:30 == 33.9	4/2/25 20:00 == 33.7	4/3/25 0:30 == 33.5	4/3/25 5:00 == 33.6
4/2/25 15:35 == 33.9	4/2/25 20:05 == 33.8	4/3/25 0:35 == 37.3	4/3/25 5:05 == 33.6
4/2/25 15:40 == 34	4/2/25 20:10 == 33.7	4/3/25 0:40 == 47.6	4/3/25 5:10 == 33.8
4/2/25 15:45 == 34	4/2/25 20:15 == 33.6	4/3/25 0:45 == 47.9	4/3/25 5:15 == 33.8
4/2/25 15:50 == 33.9	4/2/25 20:20 == 33.6	4/3/25 0:50 == 48.1	4/3/25 5:20 == 33.8
4/2/25 15:55 == 33.9	4/2/25 20:25 == 34.1	4/3/25 0:55 == 48.3	4/3/25 5:25 == 33.8
4/2/25 16:00 == 34	4/2/25 20:30 == 34	4/3/25 1:00 == 47.5	4/3/25 5:30 == 33.7
4/2/25 16:05 == 34	4/2/25 20:35 == 34	4/3/25 1:05 == 41.9	4/3/25 5:35 == 33.7
4/2/25 16:10 == 34	4/2/25 20:40 == 34	4/3/25 1:10 == 33.7	4/3/25 5:40 == 33.8
4/2/25 16:15 == 34	4/2/25 20:45 == 34	4/3/25 1:15 == 33.7	4/3/25 5:45 == 33.7
4/2/25 16:20 == 33.9	4/2/25 20:50 == 33.9	4/3/25 1:20 == 33.7	4/3/25 5:50 == 33.7
4/2/25 16:25 == 33.7	4/2/25 20:55 == 33.6	4/3/25 1:25 == 33.6	4/3/25 5:55 == 33.8

Pumpback Station Discharge (0364)

4/3/25 6:00 == 33.8	4/3/25 10:30 == 47.9	4/3/25 15:00 == 31.9	4/3/25 19:30 == 31.8
4/3/25 6:05 == 33.7	4/3/25 10:35 == 48	4/3/25 15:05 == 31.9	4/3/25 19:35 == 31.9
4/3/25 6:10 == 34	4/3/25 10:40 == 47.7	4/3/25 15:10 == 31.8	4/3/25 19:40 == 31.8
4/3/25 6:15 == 33.8	4/3/25 10:45 == 47.4	4/3/25 15:15 == 31.8	4/3/25 19:45 == 31.8
4/3/25 6:20 == 33.8	4/3/25 10:50 == 47.8	4/3/25 15:20 == 31.9	4/3/25 19:50 == 34.4
4/3/25 6:25 == 34	4/3/25 10:55 == 47.5	4/3/25 15:25 == 31.9	4/3/25 19:55 == 44.2
4/3/25 6:30 == 33.9	4/3/25 11:00 == 47.3	4/3/25 15:30 == 31.9	4/3/25 20:00 == 46.9
4/3/25 6:35 == 33.9	4/3/25 11:05 == 43	4/3/25 15:35 == 32	4/3/25 20:05 == 46.9
4/3/25 6:40 == 34.1	4/3/25 11:10 == 33.3	4/3/25 15:40 == 31.9	4/3/25 20:10 == 46.9
4/3/25 6:45 == 34	4/3/25 11:15 == 33.1	4/3/25 15:45 == 31.8	4/3/25 20:15 == 46.9
4/3/25 6:50 == 33.9	4/3/25 11:20 == 33.1	4/3/25 15:50 == 31.8	4/3/25 20:20 == 47
4/3/25 6:55 == 33.9	4/3/25 11:25 == 33.3	4/3/25 15:55 == 31.8	4/3/25 20:25 == 46.9
4/3/25 7:00 == 33.9	4/3/25 11:30 == 32.9	4/3/25 16:00 == 31.8	4/3/25 20:30 == 47
4/3/25 7:05 == 33.9	4/3/25 11:35 == 32.9	4/3/25 16:05 == 31.8	4/3/25 20:35 == 41.8
4/3/25 7:10 == 34.2	4/3/25 11:40 == 32.8	4/3/25 16:10 == 31.9	4/3/25 20:40 == 34.4
4/3/25 7:15 == 34.2	4/3/25 11:45 == 32.8	4/3/25 16:15 == 31.9	4/3/25 20:45 == 31.9
4/3/25 7:20 == 34.2	4/3/25 11:50 == 32.9	4/3/25 16:20 == 31.8	4/3/25 20:50 == 32
4/3/25 7:25 == 34.1	4/3/25 11:55 == 33	4/3/25 16:25 == 31.9	4/3/25 20:55 == 32
4/3/25 7:30 == 33.9	4/3/25 12:00 == 33.1	4/3/25 16:30 == 31.9	4/3/25 21:00 == 31.9
4/3/25 7:35 == 34	4/3/25 12:05 == 33.1	4/3/25 16:35 == 31.9	4/3/25 21:05 == 31.9
4/3/25 7:40 == 33.9	4/3/25 12:10 == 33	4/3/25 16:40 == 31.9	4/3/25 21:10 == 32
4/3/25 7:45 == 33.9	4/3/25 12:15 == 33	4/3/25 16:45 == 31.9	4/3/25 21:15 == 32.1
4/3/25 7:50 == 34.1	4/3/25 12:20 == 33	4/3/25 16:50 == 33.1	4/3/25 21:20 == 32
4/3/25 7:55 == 34.2	4/3/25 12:25 == 33	4/3/25 16:55 == 46.1	4/3/25 21:25 == 31.9
4/3/25 8:00 == 34	4/3/25 12:30 == 33	4/3/25 17:00 == 46.9	4/3/25 21:30 == 31.9
4/3/25 8:05 == 34	4/3/25 12:35 == 33	4/3/25 17:05 == 46.9	4/3/25 21:35 == 31.9
4/3/25 8:10 == 33.8	4/3/25 12:40 == 33	4/3/25 17:10 == 47	4/3/25 21:40 == 32
4/3/25 8:15 == 33.5	4/3/25 12:45 == 33	4/3/25 17:15 == 47	4/3/25 21:45 == 32
4/3/25 8:20 == 33.5	4/3/25 12:50 == 33	4/3/25 17:20 == 47	4/3/25 21:50 == 31.9
4/3/25 8:25 == 33.5	4/3/25 12:55 == 33	4/3/25 17:25 == 47	4/3/25 21:55 == 32
4/3/25 8:30 == 33.7	4/3/25 13:00 == 33.1	4/3/25 17:30 == 47	4/3/25 22:00 == 31.9
4/3/25 8:35 == 33.4	4/3/25 13:05 == 33.1	4/3/25 17:35 == 41	4/3/25 22:05 == 31.9
4/3/25 8:40 == 33.6	4/3/25 13:10 == 33.1	4/3/25 17:40 == 34.2	4/3/25 22:10 == 32
4/3/25 8:45 == 33.4	4/3/25 13:15 == 33.1	4/3/25 17:45 == 32	4/3/25 22:15 == 31.9
4/3/25 8:50 == 33.5	4/3/25 13:20 == 33	4/3/25 17:50 == 31.9	4/3/25 22:20 == 34.1
4/3/25 8:55 == 33.7	4/3/25 13:25 == 33.1	4/3/25 17:55 == 31.9	4/3/25 22:25 == 44.4
4/3/25 9:00 == 33.5	4/3/25 13:30 == 33	4/3/25 18:00 == 31.9	4/3/25 22:30 == 46.9
4/3/25 9:05 == 33.4	4/3/25 13:35 == 32.9	4/3/25 18:05 == 31.9	4/3/25 22:35 == 47.1
4/3/25 9:10 == 33.7	4/3/25 13:40 == 33.1	4/3/25 18:10 == 31.9	4/3/25 22:40 == 46.8
4/3/25 9:15 == 33.6	4/3/25 13:45 == 32.9	4/3/25 18:15 == 32	4/3/25 22:45 == 46.8
4/3/25 9:20 == 33.6	4/3/25 13:50 == 33	4/3/25 18:20 == 32	4/3/25 22:50 == 47
4/3/25 9:25 == 33.7	4/3/25 13:55 == 33.1	4/3/25 18:25 == 31.9	4/3/25 22:55 == 46.7
4/3/25 9:30 == 33.5	4/3/25 14:00 == 33.1	4/3/25 18:30 == 31.9	4/3/25 23:00 == 46.8
4/3/25 9:35 == 33.5	4/3/25 14:05 == 34.5	4/3/25 18:35 == 31.9	4/3/25 23:05 == 41.7
4/3/25 9:40 == 33.6	4/3/25 14:10 == 47.2	4/3/25 18:40 == 31.8	4/3/25 23:10 == 34.5
4/3/25 9:45 == 33.7	4/3/25 14:15 == 47.9	4/3/25 18:45 == 31.7	4/3/25 23:15 == 31.9
4/3/25 9:50 == 33.7	4/3/25 14:20 == 47.9	4/3/25 18:50 == 31.9	4/3/25 23:20 == 31.9
4/3/25 9:55 == 33.6	4/3/25 14:25 == 48	4/3/25 18:55 == 31.9	4/3/25 23:25 == 31.9
4/3/25 10:00 == 33.7	4/3/25 14:30 == 48.1	4/3/25 19:00 == 31.9	4/3/25 23:30 == 31.9
4/3/25 10:05 == 33.5	4/3/25 14:35 == 41.8	4/3/25 19:05 == 32	4/3/25 23:35 == 31.9
4/3/25 10:10 == 33.3	4/3/25 14:40 == 34.4	4/3/25 19:10 == 32	4/3/25 23:40 == 32
4/3/25 10:15 == 33.4	4/3/25 14:45 == 32.9	4/3/25 19:15 == 31.8	4/3/25 23:45 == 31.9
4/3/25 10:20 == 38.1	4/3/25 14:50 == 32.8	4/3/25 19:20 == 32	4/3/25 23:50 == 31.9
4/3/25 10:25 == 45.1	4/3/25 14:55 == 32.1	4/3/25 19:25 == 31.9	4/3/25 23:55 == 31.8

Pumpback Station Discharge (0364)

4/4/25 0:00 == 31.9	4/4/25 4:30 == 31.9	4/4/25 9:00 == 31.9	4/4/25 13:30 == 35.5
4/4/25 0:05 == 31.8	4/4/25 4:35 == 31.9	4/4/25 9:05 == 31.9	4/4/25 13:35 == 35.4
4/4/25 0:10 == 31.9	4/4/25 4:40 == 32	4/4/25 9:10 == 31.9	4/4/25 13:40 == 35.2
4/4/25 0:15 == 32	4/4/25 4:45 == 31.9	4/4/25 9:15 == 31.9	4/4/25 13:45 == 35.4
4/4/25 0:20 == 31.9	4/4/25 4:50 == 32	4/4/25 9:20 == 31.8	4/4/25 13:50 == 35.4
4/4/25 0:25 == 31.9	4/4/25 4:55 == 31.9	4/4/25 9:25 == 31.8	4/4/25 13:55 == 35.4
4/4/25 0:30 == 31.9	4/4/25 5:00 == 31.9	4/4/25 9:30 == 31.9	4/4/25 14:00 == 35.5
4/4/25 0:35 == 31.9	4/4/25 5:05 == 31.9	4/4/25 9:35 == 32	4/4/25 14:05 == 35.5
4/4/25 0:40 == 31.9	4/4/25 5:10 == 31.9	4/4/25 9:40 == 32	4/4/25 14:10 == 35.3
4/4/25 0:45 == 31.9	4/4/25 5:15 == 31.9	4/4/25 9:45 == 31.9	4/4/25 14:15 == 35.1
4/4/25 0:50 == 32	4/4/25 5:20 == 33	4/4/25 9:50 == 31.9	4/4/25 14:20 == 35.2
4/4/25 0:55 == 32	4/4/25 5:25 == 43.6	4/4/25 9:55 == 31.8	4/4/25 14:25 == 35.1
4/4/25 1:00 == 31.9	4/4/25 5:30 == 46.8	4/4/25 10:00 == 31.9	4/4/25 14:30 == 34.9
4/4/25 1:05 == 31.9	4/4/25 5:35 == 47	4/4/25 10:05 == 32	4/4/25 14:35 == 35.7
4/4/25 1:10 == 31.9	4/4/25 5:40 == 46.8	4/4/25 10:10 == 32	4/4/25 14:40 == 42
4/4/25 1:15 == 31.9	4/4/25 5:45 == 47.1	4/4/25 10:15 == 32	4/4/25 14:45 == 47.9
4/4/25 1:20 == 31.9	4/4/25 5:50 == 46.9	4/4/25 10:20 == 32	4/4/25 14:50 == 48.1
4/4/25 1:25 == 31.9	4/4/25 5:55 == 47	4/4/25 10:25 == 32	4/4/25 14:55 == 48.1
4/4/25 1:30 == 31.9	4/4/25 6:00 == 47	4/4/25 10:30 == 32.1	4/4/25 15:00 == 48
4/4/25 1:35 == 35	4/4/25 6:05 == 43.7	4/4/25 10:35 == 32	4/4/25 15:05 == 48
4/4/25 1:40 == 42.6	4/4/25 6:10 == 34.1	4/4/25 10:40 == 32	4/4/25 15:10 == 48.2
4/4/25 1:45 == 46.9	4/4/25 6:15 == 31.8	4/4/25 10:45 == 32.2	4/4/25 15:15 == 48.1
4/4/25 1:50 == 46.8	4/4/25 6:20 == 31.9	4/4/25 10:50 == 32.2	4/4/25 15:20 == 46
4/4/25 1:55 == 46.9	4/4/25 6:25 == 31.9	4/4/25 10:55 == 32.2	4/4/25 15:25 == 37.9
4/4/25 2:00 == 46.9	4/4/25 6:30 == 31.9	4/4/25 11:00 == 32.5	4/4/25 15:30 == 35.1
4/4/25 2:05 == 46.9	4/4/25 6:35 == 31.9	4/4/25 11:05 == 33	4/4/25 15:35 == 35.2
4/4/25 2:10 == 46.8	4/4/25 6:40 == 31.8	4/4/25 11:10 == 33.1	4/4/25 15:40 == 35.3
4/4/25 2:15 == 46.8	4/4/25 6:45 == 31.8	4/4/25 11:15 == 32.9	4/4/25 15:45 == 35.1
4/4/25 2:20 == 43.4	4/4/25 6:50 == 31.9	4/4/25 11:20 == 33.3	4/4/25 15:50 == 35.2
4/4/25 2:25 == 33.2	4/4/25 6:55 == 31.9	4/4/25 11:25 == 33.3	4/4/25 15:55 == 35.1
4/4/25 2:30 == 31.8	4/4/25 7:00 == 31.9	4/4/25 11:30 == 33.3	4/4/25 16:00 == 35.3
4/4/25 2:35 == 32	4/4/25 7:05 == 32	4/4/25 11:35 == 33.3	4/4/25 16:05 == 35.2
4/4/25 2:40 == 31.9	4/4/25 7:10 == 31.9	4/4/25 11:40 == 33.2	4/4/25 16:10 == 35.1
4/4/25 2:45 == 31.9	4/4/25 7:15 == 31.8	4/4/25 11:45 == 33.3	4/4/25 16:15 == 34.9
4/4/25 2:50 == 31.8	4/4/25 7:20 == 31.9	4/4/25 11:50 == 33.3	4/4/25 16:20 == 34.9
4/4/25 2:55 == 31.9	4/4/25 7:25 == 31.8	4/4/25 11:55 == 33.4	4/4/25 16:25 == 34.8
4/4/25 3:00 == 31.9	4/4/25 7:30 == 31.9	4/4/25 12:00 == 33.4	4/4/25 16:30 == 34.6
4/4/25 3:05 == 31.9	4/4/25 7:35 == 31.9	4/4/25 12:05 == 33.4	4/4/25 16:35 == 34.8
4/4/25 3:10 == 31.9	4/4/25 7:40 == 31.8	4/4/25 12:10 == 33.5	4/4/25 16:40 == 35
4/4/25 3:15 == 31.9	4/4/25 7:45 == 31.8	4/4/25 12:15 == 33.5	4/4/25 16:45 == 35
4/4/25 3:20 == 31.9	4/4/25 7:50 == 31.8	4/4/25 12:20 == 33.6	4/4/25 16:50 == 34.8
4/4/25 3:25 == 32	4/4/25 7:55 == 31.9	4/4/25 12:25 == 33.7	4/4/25 16:55 == 35
4/4/25 3:30 == 32	4/4/25 8:00 == 32	4/4/25 12:30 == 33.8	4/4/25 17:00 == 35.1
4/4/25 3:35 == 31.9	4/4/25 8:05 == 31.9	4/4/25 12:35 == 34	4/4/25 17:05 == 35.1
4/4/25 3:40 == 31.9	4/4/25 8:10 == 32	4/4/25 12:40 == 34.4	4/4/25 17:10 == 35.5
4/4/25 3:45 == 32	4/4/25 8:15 == 31.8	4/4/25 12:45 == 34.5	4/4/25 17:15 == 35.7
4/4/25 3:50 == 32	4/4/25 8:20 == 31.9	4/4/25 12:50 == 34.4	4/4/25 17:20 == 35.5
4/4/25 3:55 == 32	4/4/25 8:25 == 31.9	4/4/25 12:55 == 34.6	4/4/25 17:25 == 35.5
4/4/25 4:00 == 31.9	4/4/25 8:30 == 32	4/4/25 13:00 == 34.7	4/4/25 17:30 == 35.5
4/4/25 4:05 == 31.9	4/4/25 8:35 == 32	4/4/25 13:05 == 34.7	4/4/25 17:35 == 35.6
4/4/25 4:10 == 31.9	4/4/25 8:40 == 31.9	4/4/25 13:10 == 35	4/4/25 17:40 == 35.8
4/4/25 4:15 == 31.8	4/4/25 8:45 == 32	4/4/25 13:15 == 35.1	4/4/25 17:45 == 35.7
4/4/25 4:20 == 31.8	4/4/25 8:50 == 31.9	4/4/25 13:20 == 35.1	4/4/25 17:50 == 35.7
4/4/25 4:25 == 31.9	4/4/25 8:55 == 31.9	4/4/25 13:25 == 35.6	4/4/25 17:55 == 35.6

Pumpback Station Discharge (0364)

4/4/25 18:00 == 35.5	4/4/25 22:30 == 35.8	4/5/25 3:00 == 33.7	4/5/25 7:30 == 34.4
4/4/25 18:05 == 35.4	4/4/25 22:35 == 35.7	4/5/25 3:05 == 33.7	4/5/25 7:35 == 34.5
4/4/25 18:10 == 35.4	4/4/25 22:40 == 35.5	4/5/25 3:10 == 34	4/5/25 7:40 == 34.4
4/4/25 18:15 == 35	4/4/25 22:45 == 35.2	4/5/25 3:15 == 33.9	4/5/25 7:45 == 34.4
4/4/25 18:20 == 34.9	4/4/25 22:50 == 34.5	4/5/25 3:20 == 33.8	4/5/25 7:50 == 34.4
4/4/25 18:25 == 35.1	4/4/25 22:55 == 34.3	4/5/25 3:25 == 33.7	4/5/25 7:55 == 34.2
4/4/25 18:30 == 35.2	4/4/25 23:00 == 34.2	4/5/25 3:30 == 33.7	4/5/25 8:00 == 34.1
4/4/25 18:35 == 35.1	4/4/25 23:05 == 34.2	4/5/25 3:35 == 33.7	4/5/25 8:05 == 33.9
4/4/25 18:40 == 35.1	4/4/25 23:10 == 34.1	4/5/25 3:40 == 33.9	4/5/25 8:10 == 33.8
4/4/25 18:45 == 35	4/4/25 23:15 == 34.1	4/5/25 3:45 == 34	4/5/25 8:15 == 33.5
4/4/25 18:50 == 34.8	4/4/25 23:20 == 34.1	4/5/25 3:50 == 33.8	4/5/25 8:20 == 33.5
4/4/25 18:55 == 34.9	4/4/25 23:25 == 33.9	4/5/25 3:55 == 33.8	4/5/25 8:25 == 33.5
4/4/25 19:00 == 35	4/4/25 23:30 == 34.1	4/5/25 4:00 == 33.9	4/5/25 8:30 == 33.6
4/4/25 19:05 == 35.1	4/4/25 23:35 == 34	4/5/25 4:05 == 33.8	4/5/25 8:35 == 33.8
4/4/25 19:10 == 35.1	4/4/25 23:40 == 33.9	4/5/25 4:10 == 33.9	4/5/25 8:40 == 33.8
4/4/25 19:15 == 35.2	4/4/25 23:45 == 33.5	4/5/25 4:15 == 33.9	4/5/25 8:45 == 33.8
4/4/25 19:20 == 35.1	4/4/25 23:50 == 33.5	4/5/25 4:20 == 34	4/5/25 8:50 == 33.9
4/4/25 19:25 == 35.2	4/4/25 23:55 == 33.4	4/5/25 4:25 == 34.1	4/5/25 8:55 == 34.1
4/4/25 19:30 == 35	4/5/25 0:00 == 33.4	4/5/25 4:30 == 33.9	4/5/25 9:00 == 34.3
4/4/25 19:35 == 34.8	4/5/25 0:05 == 33.5	4/5/25 4:35 == 34	4/5/25 9:05 == 34.2
4/4/25 19:40 == 34.8	4/5/25 0:10 == 33.7	4/5/25 4:40 == 33.9	4/5/25 9:10 == 34.3
4/4/25 19:45 == 35	4/5/25 0:15 == 33.8	4/5/25 4:45 == 33.8	4/5/25 9:15 == 34.3
4/4/25 19:50 == 35.1	4/5/25 0:20 == 33.8	4/5/25 4:50 == 33.9	4/5/25 9:20 == 34.4
4/4/25 19:55 == 35	4/5/25 0:25 == 33.9	4/5/25 4:55 == 34	4/5/25 9:25 == 34.6
4/4/25 20:00 == 35	4/5/25 0:30 == 34	4/5/25 5:00 == 33.9	4/5/25 9:30 == 34.4
4/4/25 20:05 == 35	4/5/25 0:35 == 34	4/5/25 5:05 == 33.8	4/5/25 9:35 == 34.6
4/4/25 20:10 == 34.9	4/5/25 0:40 == 33.9	4/5/25 5:10 == 33.9	4/5/25 9:40 == 34.7
4/4/25 20:15 == 35	4/5/25 0:45 == 33.9	4/5/25 5:15 == 34.1	4/5/25 9:45 == 34.5
4/4/25 20:20 == 35.1	4/5/25 0:50 == 33.7	4/5/25 5:20 == 34.1	4/5/25 9:50 == 34.8
4/4/25 20:25 == 35.4	4/5/25 0:55 == 33.5	4/5/25 5:25 == 33.9	4/5/25 9:55 == 34.6
4/4/25 20:30 == 35.8	4/5/25 1:00 == 33.5	4/5/25 5:30 == 33.9	4/5/25 10:00 == 34.5
4/4/25 20:35 == 35.3	4/5/25 1:05 == 33.6	4/5/25 5:35 == 33.9	4/5/25 10:05 == 34.2
4/4/25 20:40 == 35.4	4/5/25 1:10 == 33.6	4/5/25 5:40 == 34.1	4/5/25 10:10 == 34.1
4/4/25 20:45 == 35.3	4/5/25 1:15 == 33.5	4/5/25 5:45 == 34.1	4/5/25 10:15 == 33.9
4/4/25 20:50 == 35.3	4/5/25 1:20 == 33.6	4/5/25 5:50 == 34.1	4/5/25 10:20 == 34.2
4/4/25 20:55 == 35.1	4/5/25 1:25 == 33.5	4/5/25 5:55 == 34	4/5/25 10:25 == 34.4
4/4/25 21:00 == 35	4/5/25 1:30 == 33.3	4/5/25 6:00 == 34	4/5/25 10:30 == 34.3
4/4/25 21:05 == 35	4/5/25 1:35 == 33.5	4/5/25 6:05 == 34.1	4/5/25 10:35 == 34.5
4/4/25 21:10 == 34.9	4/5/25 1:40 == 33.4	4/5/25 6:10 == 34.2	4/5/25 10:40 == 34.9
4/4/25 21:15 == 35	4/5/25 1:45 == 33.4	4/5/25 6:15 == 34.3	4/5/25 10:45 == 35
4/4/25 21:20 == 35	4/5/25 1:50 == 33.5	4/5/25 6:20 == 34.4	4/5/25 10:50 == 34.7
4/4/25 21:25 == 34.8	4/5/25 1:55 == 33.9	4/5/25 6:25 == 34.4	4/5/25 10:55 == 34.6
4/4/25 21:30 == 34.6	4/5/25 2:00 == 33.9	4/5/25 6:30 == 34.4	4/5/25 11:00 == 34.6
4/4/25 21:35 == 34.6	4/5/25 2:05 == 33.8	4/5/25 6:35 == 34.5	4/5/25 11:05 == 34.6
4/4/25 21:40 == 35.1	4/5/25 2:10 == 33.9	4/5/25 6:40 == 34.5	4/5/25 11:10 == 34.9
4/4/25 21:45 == 35.3	4/5/25 2:15 == 33.6	4/5/25 6:45 == 34.4	4/5/25 11:15 == 35.1
4/4/25 21:50 == 35.6	4/5/25 2:20 == 33.8	4/5/25 6:50 == 34.3	4/5/25 11:20 == 35.1
4/4/25 21:55 == 35.6	4/5/25 2:25 == 33.8	4/5/25 6:55 == 34.5	4/5/25 11:25 == 35.4
4/4/25 22:00 == 35.6	4/5/25 2:30 == 34	4/5/25 7:00 == 34.5	4/5/25 11:30 == 35.3
4/4/25 22:05 == 35.6	4/5/25 2:35 == 34.1	4/5/25 7:05 == 34.5	4/5/25 11:35 == 35
4/4/25 22:10 == 35.6	4/5/25 2:40 == 33.9	4/5/25 7:10 == 34.8	4/5/25 11:40 == 34.8
4/4/25 22:15 == 35.3	4/5/25 2:45 == 33.8	4/5/25 7:15 == 34.5	4/5/25 11:45 == 34.7
4/4/25 22:20 == 35.3	4/5/25 2:50 == 33.9	4/5/25 7:20 == 34.7	4/5/25 11:50 == 34.5
4/4/25 22:25 == 35.6	4/5/25 2:55 == 33.7	4/5/25 7:25 == 34.6	4/5/25 11:55 == 34.4

Pumpback Station Discharge (0364)

4/5/25 12:00 == 33.8	4/5/25 16:30 == 34.5	4/5/25 21:00 == 34.1	4/6/25 1:30 == 34.1
4/5/25 12:05 == 34.2	4/5/25 16:35 == 34.7	4/5/25 21:05 == 34.4	4/6/25 1:35 == 34.2
4/5/25 12:10 == 33.9	4/5/25 16:40 == 34.7	4/5/25 21:10 == 34.7	4/6/25 1:40 == 34.2
4/5/25 12:15 == 33.5	4/5/25 16:45 == 34.7	4/5/25 21:15 == 34.7	4/6/25 1:45 == 34.3
4/5/25 12:20 == 33.5	4/5/25 16:50 == 35	4/5/25 21:20 == 34.8	4/6/25 1:50 == 34.3
4/5/25 12:25 == 33.5	4/5/25 16:55 == 35	4/5/25 21:25 == 34.9	4/6/25 1:55 == 34.9
4/5/25 12:30 == 33.7	4/5/25 17:00 == 34.7	4/5/25 21:30 == 34.5	4/6/25 2:00 == 34.7
4/5/25 12:35 == 33.7	4/5/25 17:05 == 34.6	4/5/25 21:35 == 34.2	4/6/25 2:05 == 34.6
4/5/25 12:40 == 33.7	4/5/25 17:10 == 34.5	4/5/25 21:40 == 34.3	4/6/25 2:10 == 34.4
4/5/25 12:45 == 33.6	4/5/25 17:15 == 34.6	4/5/25 21:45 == 34.4	4/6/25 2:15 == 34.5
4/5/25 12:50 == 33.8	4/5/25 17:20 == 34.5	4/5/25 21:50 == 34.4	4/6/25 2:20 == 34.5
4/5/25 12:55 == 33.8	4/5/25 17:25 == 34.5	4/5/25 21:55 == 34.5	4/6/25 2:25 == 34.7
4/5/25 13:00 == 33.7	4/5/25 17:30 == 34.4	4/5/25 22:00 == 35	4/6/25 2:30 == 34.9
4/5/25 13:05 == 34	4/5/25 17:35 == 34.7	4/5/25 22:05 == 35	4/6/25 2:35 == 35
4/5/25 13:10 == 34.2	4/5/25 17:40 == 34.9	4/5/25 22:10 == 34.8	4/6/25 2:40 == 34.9
4/5/25 13:15 == 34.3	4/5/25 17:45 == 35	4/5/25 22:15 == 34.5	4/6/25 2:45 == 34.7
4/5/25 13:20 == 34.3	4/5/25 17:50 == 35.2	4/5/25 22:20 == 34.4	4/6/25 2:50 == 34.5
4/5/25 13:25 == 34.4	4/5/25 17:55 == 35.1	4/5/25 22:25 == 34.4	4/6/25 2:55 == 34.2
4/5/25 13:30 == 34.6	4/5/25 18:00 == 34.4	4/5/25 22:30 == 34.3	4/6/25 3:00 == 33.9
4/5/25 13:35 == 34.6	4/5/25 18:05 == 34.3	4/5/25 22:35 == 34.5	4/6/25 3:05 == 34.1
4/5/25 13:40 == 34.7	4/5/25 18:10 == 34.4	4/5/25 22:40 == 34.7	4/6/25 3:10 == 34.4
4/5/25 13:45 == 34.8	4/5/25 18:15 == 34.7	4/5/25 22:45 == 34.7	4/6/25 3:15 == 34.6
4/5/25 13:50 == 34.9	4/5/25 18:20 == 34.8	4/5/25 22:50 == 34.6	4/6/25 3:20 == 34.5
4/5/25 13:55 == 35.1	4/5/25 18:25 == 34.9	4/5/25 22:55 == 34.7	4/6/25 3:25 == 34.4
4/5/25 14:00 == 35.2	4/5/25 18:30 == 34.7	4/5/25 23:00 == 34.7	4/6/25 3:30 == 34.2
4/5/25 14:05 == 34.9	4/5/25 18:35 == 34.6	4/5/25 23:05 == 34.7	4/6/25 3:35 == 34.4
4/5/25 14:10 == 34.7	4/5/25 18:40 == 34.3	4/5/25 23:10 == 34.2	4/6/25 3:40 == 34.5
4/5/25 14:15 == 34.6	4/5/25 18:45 == 33.9	4/5/25 23:15 == 34.1	4/6/25 3:45 == 34.2
4/5/25 14:20 == 34.3	4/5/25 18:50 == 33.8	4/5/25 23:20 == 34.2	4/6/25 3:50 == 34.2
4/5/25 14:25 == 34.4	4/5/25 18:55 == 34	4/5/25 23:25 == 34.3	4/6/25 3:55 == 34.4
4/5/25 14:30 == 34.1	4/5/25 19:00 == 34.2	4/5/25 23:30 == 34.3	4/6/25 4:00 == 34.3
4/5/25 14:35 == 34.4	4/5/25 19:05 == 34.3	4/5/25 23:35 == 34.5	4/6/25 4:05 == 34.3
4/5/25 14:40 == 34.9	4/5/25 19:10 == 34.5	4/5/25 23:40 == 34.3	4/6/25 4:10 == 34.5
4/5/25 14:45 == 34.6	4/5/25 19:15 == 34.6	4/5/25 23:45 == 34.2	4/6/25 4:15 == 34.6
4/5/25 14:50 == 34.7	4/5/25 19:20 == 34.6	4/5/25 23:50 == 34.4	4/6/25 4:20 == 34.6
4/5/25 14:55 == 35.1	4/5/25 19:25 == 34.6	4/5/25 23:55 == 34.3	4/6/25 4:25 == 34.9
4/5/25 15:00 == 34.8	4/5/25 19:30 == 34.5	4/6/25 0:00 == 34.1	4/6/25 4:30 == 35
4/5/25 15:05 == 35.1	4/5/25 19:35 == 34.4	4/6/25 0:05 == 34.1	4/6/25 4:35 == 34.6
4/5/25 15:10 == 34.8	4/5/25 19:40 == 34.2	4/6/25 0:10 == 34	4/6/25 4:40 == 34.2
4/5/25 15:15 == 34.7	4/5/25 19:45 == 34.2	4/6/25 0:15 == 33.9	4/6/25 4:45 == 34.1
4/5/25 15:20 == 34.3	4/5/25 19:50 == 34.4	4/6/25 0:20 == 33.8	4/6/25 4:50 == 34.4
4/5/25 15:25 == 34.5	4/5/25 19:55 == 34.5	4/6/25 0:25 == 33.8	4/6/25 4:55 == 34.7
4/5/25 15:30 == 34.6	4/5/25 20:00 == 34.6	4/6/25 0:30 == 33.9	4/6/25 5:00 == 34.9
4/5/25 15:35 == 34.7	4/5/25 20:05 == 34.7	4/6/25 0:35 == 34.1	4/6/25 5:05 == 34.8
4/5/25 15:40 == 34.7	4/5/25 20:10 == 34.7	4/6/25 0:40 == 34.3	4/6/25 5:10 == 35
4/5/25 15:45 == 34.9	4/5/25 20:15 == 34.3	4/6/25 0:45 == 34.4	4/6/25 5:15 == 34.9
4/5/25 15:50 == 35.1	4/5/25 20:20 == 34.1	4/6/25 0:50 == 34.2	4/6/25 5:20 == 34.5
4/5/25 15:55 == 35.3	4/5/25 20:25 == 34.6	4/6/25 0:55 == 34.1	4/6/25 5:25 == 34.3
4/5/25 16:00 == 35.2	4/5/25 20:30 == 34.8	4/6/25 1:00 == 33.8	4/6/25 5:30 == 34.4
4/5/25 16:05 == 34.8	4/5/25 20:35 == 35	4/6/25 1:05 == 34	4/6/25 5:35 == 34.6
4/5/25 16:10 == 34.9	4/5/25 20:40 == 35.1	4/6/25 1:10 == 33.9	4/6/25 5:40 == 34.7
4/5/25 16:15 == 34.6	4/5/25 20:45 == 34.8	4/6/25 1:15 == 34.1	4/6/25 5:45 == 34.8
4/5/25 16:20 == 34.5	4/5/25 20:50 == 34.6	4/6/25 1:20 == 34	4/6/25 5:50 == 34.6
4/5/25 16:25 == 34.5	4/5/25 20:55 == 34.2	4/6/25 1:25 == 34.1	4/6/25 5:55 == 34.5

Pumpback Station Discharge (0364)

4/6/25 6:00 == 34.6	4/6/25 10:30 == 34.1	4/6/25 15:00 == 34.9	4/6/25 19:30 == 34.6
4/6/25 6:05 == 34.6	4/6/25 10:35 == 34.2	4/6/25 15:05 == 34.9	4/6/25 19:35 == 34.4
4/6/25 6:10 == 34.9	4/6/25 10:40 == 34.8	4/6/25 15:10 == 34.9	4/6/25 19:40 == 34.4
4/6/25 6:15 == 34.8	4/6/25 10:45 == 35.2	4/6/25 15:15 == 35	4/6/25 19:45 == 34.3
4/6/25 6:20 == 34.9	4/6/25 10:50 == 35.2	4/6/25 15:20 == 35.1	4/6/25 19:50 == 34.2
4/6/25 6:25 == 34.8	4/6/25 10:55 == 35.2	4/6/25 15:25 == 35	4/6/25 19:55 == 34.3
4/6/25 6:30 == 35.2	4/6/25 11:00 == 35.2	4/6/25 15:30 == 34.9	4/6/25 20:00 == 34.5
4/6/25 6:35 == 35.3	4/6/25 11:05 == 35	4/6/25 15:35 == 34.9	4/6/25 20:05 == 34.7
4/6/25 6:40 == 35.3	4/6/25 11:10 == 35.1	4/6/25 15:40 == 35	4/6/25 20:10 == 34.8
4/6/25 6:45 == 34.6	4/6/25 11:15 == 35.2	4/6/25 15:45 == 35.1	4/6/25 20:15 == 34.7
4/6/25 6:50 == 34.3	4/6/25 11:20 == 35.1	4/6/25 15:50 == 35	4/6/25 20:20 == 34.8
4/6/25 6:55 == 34.8	4/6/25 11:25 == 35.1	4/6/25 15:55 == 35.1	4/6/25 20:25 == 35.2
4/6/25 7:00 == 34.9	4/6/25 11:30 == 35.3	4/6/25 16:00 == 35.4	4/6/25 20:30 == 35
4/6/25 7:05 == 35	4/6/25 11:35 == 35.2	4/6/25 16:05 == 35.5	4/6/25 20:35 == 34.6
4/6/25 7:10 == 35.5	4/6/25 11:40 == 35.4	4/6/25 16:10 == 35.7	4/6/25 20:40 == 34.5
4/6/25 7:15 == 35.1	4/6/25 11:45 == 35.2	4/6/25 16:15 == 35.7	4/6/25 20:45 == 34.3
4/6/25 7:20 == 34.8	4/6/25 11:50 == 35.1	4/6/25 16:20 == 35.4	4/6/25 20:50 == 34.3
4/6/25 7:25 == 34.6	4/6/25 11:55 == 35.3	4/6/25 16:25 == 35.1	4/6/25 20:55 == 34.4
4/6/25 7:30 == 34.4	4/6/25 12:00 == 34.7	4/6/25 16:30 == 34.9	4/6/25 21:00 == 34.6
4/6/25 7:35 == 34.4	4/6/25 12:05 == 34.8	4/6/25 16:35 == 34.8	4/6/25 21:05 == 34.6
4/6/25 7:40 == 34.6	4/6/25 12:10 == 35.1	4/6/25 16:40 == 34.7	4/6/25 21:10 == 34.7
4/6/25 7:45 == 34.6	4/6/25 12:15 == 34.8	4/6/25 16:45 == 34.6	4/6/25 21:15 == 35
4/6/25 7:50 == 34.6	4/6/25 12:20 == 34.8	4/6/25 16:50 == 34.8	4/6/25 21:20 == 35
4/6/25 7:55 == 34.5	4/6/25 12:25 == 34.6	4/6/25 16:55 == 35	4/6/25 21:25 == 34.8
4/6/25 8:00 == 34.6	4/6/25 12:30 == 34.5	4/6/25 17:00 == 34.8	4/6/25 21:30 == 34.3
4/6/25 8:05 == 34.8	4/6/25 12:35 == 34.3	4/6/25 17:05 == 35.2	4/6/25 21:35 == 34.3
4/6/25 8:10 == 34.8	4/6/25 12:40 == 34.2	4/6/25 17:10 == 35.3	4/6/25 21:40 == 34.5
4/6/25 8:15 == 34.6	4/6/25 12:45 == 34.2	4/6/25 17:15 == 35.4	4/6/25 21:45 == 34.8
4/6/25 8:20 == 34.3	4/6/25 12:50 == 34.2	4/6/25 17:20 == 35.5	4/6/25 21:50 == 35
4/6/25 8:25 == 34.1	4/6/25 12:55 == 34.1	4/6/25 17:25 == 35.3	4/6/25 21:55 == 35.2
4/6/25 8:30 == 34	4/6/25 13:00 == 34.2	4/6/25 17:30 == 35	4/6/25 22:00 == 35.2
4/6/25 8:35 == 33.9	4/6/25 13:05 == 34.2	4/6/25 17:35 == 34.8	4/6/25 22:05 == 34.8
4/6/25 8:40 == 34.2	4/6/25 13:10 == 34.4	4/6/25 17:40 == 34.7	4/6/25 22:10 == 34.7
4/6/25 8:45 == 34.1	4/6/25 13:15 == 34.7	4/6/25 17:45 == 34.6	4/6/25 22:15 == 34.4
4/6/25 8:50 == 34.3	4/6/25 13:20 == 34.7	4/6/25 17:50 == 34.8	4/6/25 22:20 == 34.4
4/6/25 8:55 == 34.5	4/6/25 13:25 == 34.7	4/6/25 17:55 == 34.9	4/6/25 22:25 == 34.3
4/6/25 9:00 == 34.6	4/6/25 13:30 == 34.8	4/6/25 18:00 == 34.8	4/6/25 22:30 == 34.3
4/6/25 9:05 == 34.4	4/6/25 13:35 == 34.6	4/6/25 18:05 == 34.8	4/6/25 22:35 == 34.2
4/6/25 9:10 == 34.1	4/6/25 13:40 == 34.8	4/6/25 18:10 == 34.9	4/6/25 22:40 == 34.4
4/6/25 9:15 == 33.9	4/6/25 13:45 == 34.9	4/6/25 18:15 == 34.9	4/6/25 22:45 == 34.4
4/6/25 9:20 == 33.9	4/6/25 13:50 == 34.8	4/6/25 18:20 == 34.7	4/6/25 22:50 == 34.4
4/6/25 9:25 == 26.3	4/6/25 13:55 == 34.9	4/6/25 18:25 == 34.5	4/6/25 22:55 == 34.5
4/6/25 9:30 == 18.1	4/6/25 14:00 == 34.8	4/6/25 18:30 == 34.3	4/6/25 23:00 == 34.4
4/6/25 9:35 == 17.2	4/6/25 14:05 == 34.9	4/6/25 18:35 == 34.2	4/6/25 23:05 == 34.3
4/6/25 9:40 == 17.4	4/6/25 14:10 == 35	4/6/25 18:40 == 34.1	4/6/25 23:10 == 34.4
4/6/25 9:45 == 17.5	4/6/25 14:15 == 34.9	4/6/25 18:45 == 34	4/6/25 23:15 == 34.5
4/6/25 9:50 == 17.5	4/6/25 14:20 == 34.7	4/6/25 18:50 == 33.8	4/6/25 23:20 == 34.6
4/6/25 9:55 == 23.4	4/6/25 14:25 == 34.8	4/6/25 18:55 == 34	4/6/25 23:25 == 34.7
4/6/25 10:00 == 31.6	4/6/25 14:30 == 34.6	4/6/25 19:00 == 34.4	4/6/25 23:30 == 34.5
4/6/25 10:05 == 34.2	4/6/25 14:35 == 34.5	4/6/25 19:05 == 34.4	4/6/25 23:35 == 34.2
4/6/25 10:10 == 34.1	4/6/25 14:40 == 35.1	4/6/25 19:10 == 34.5	4/6/25 23:40 == 34.1
4/6/25 10:15 == 34	4/6/25 14:45 == 35	4/6/25 19:15 == 34.5	4/6/25 23:45 == 34
4/6/25 10:20 == 34	4/6/25 14:50 == 35.1	4/6/25 19:20 == 34.6	4/6/25 23:50 == 34.2
4/6/25 10:25 == 34	4/6/25 14:55 == 35.1	4/6/25 19:25 == 34.8	4/6/25 23:55 == 34.2

Pumpback Station Discharge (0364)

4/7/25 0:00 == 34.2	4/7/25 4:30 == 34.5	4/7/25 9:00 == 34	4/7/25 13:30 == 34.2
4/7/25 0:05 == 34.3	4/7/25 4:35 == 34.5	4/7/25 9:05 == 34.1	4/7/25 13:35 == 34.3
4/7/25 0:10 == 34.3	4/7/25 4:40 == 34.5	4/7/25 9:10 == 34.2	4/7/25 13:40 == 34.6
4/7/25 0:15 == 34.2	4/7/25 4:45 == 34.6	4/7/25 9:15 == 34.2	4/7/25 13:45 == 34.8
4/7/25 0:20 == 33.9	4/7/25 4:50 == 34.9	4/7/25 9:20 == 34.2	4/7/25 13:50 == 34.9
4/7/25 0:25 == 33.9	4/7/25 4:55 == 35	4/7/25 9:25 == 34	4/7/25 13:55 == 34.8
4/7/25 0:30 == 33.9	4/7/25 5:00 == 34.7	4/7/25 9:30 == 33.7	4/7/25 14:00 == 34.9
4/7/25 0:35 == 33.9	4/7/25 5:05 == 34.4	4/7/25 9:35 == 33.6	4/7/25 14:05 == 35
4/7/25 0:40 == 34	4/7/25 5:10 == 34.4	4/7/25 9:40 == 33.8	4/7/25 14:10 == 35
4/7/25 0:45 == 34.3	4/7/25 5:15 == 34.6	4/7/25 9:45 == 34	4/7/25 14:15 == 34.8
4/7/25 0:50 == 34.3	4/7/25 5:20 == 34.6	4/7/25 9:50 == 34	4/7/25 14:20 == 34.7
4/7/25 0:55 == 34.4	4/7/25 5:25 == 34.6	4/7/25 9:55 == 34.2	4/7/25 14:25 == 34.5
4/7/25 1:00 == 34.2	4/7/25 5:30 == 34.7	4/7/25 10:00 == 34.4	4/7/25 14:30 == 34.3
4/7/25 1:05 == 34.1	4/7/25 5:35 == 34.9	4/7/25 10:05 == 34.3	4/7/25 14:35 == 34.3
4/7/25 1:10 == 34.2	4/7/25 5:40 == 35	4/7/25 10:10 == 34	4/7/25 14:40 == 34.6
4/7/25 1:15 == 34	4/7/25 5:45 == 34.6	4/7/25 10:15 == 33.9	4/7/25 14:45 == 34.6
4/7/25 1:20 == 33.9	4/7/25 5:50 == 34.5	4/7/25 10:20 == 33.9	4/7/25 14:50 == 34.5
4/7/25 1:25 == 33.9	4/7/25 5:55 == 34.4	4/7/25 10:25 == 34.2	4/7/25 14:55 == 34.6
4/7/25 1:30 == 33.8	4/7/25 6:00 == 34.6	4/7/25 10:30 == 34.2	4/7/25 15:00 == 34.6
4/7/25 1:35 == 33.8	4/7/25 6:05 == 34.5	4/7/25 10:35 == 34.3	4/7/25 15:05 == 34.5
4/7/25 1:40 == 33.9	4/7/25 6:10 == 34.2	4/7/25 10:40 == 35.1	4/7/25 15:10 == 34.6
4/7/25 1:45 == 34.1	4/7/25 6:15 == 34.2	4/7/25 10:45 == 35.3	4/7/25 15:15 == 34.7
4/7/25 1:50 == 34.1	4/7/25 6:20 == 34.3	4/7/25 10:50 == 34.8	4/7/25 15:20 == 34.7
4/7/25 1:55 == 34.7	4/7/25 6:25 == 34.8	4/7/25 10:55 == 34.5	4/7/25 15:25 == 34.8
4/7/25 2:00 == 35.2	4/7/25 6:30 == 35	4/7/25 11:00 == 34.4	4/7/25 15:30 == 34.8
4/7/25 2:05 == 35.2	4/7/25 6:35 == 34.9	4/7/25 11:05 == 34.3	4/7/25 15:35 == 34.7
4/7/25 2:10 == 35.2	4/7/25 6:40 == 35.2	4/7/25 11:10 == 34.6	4/7/25 15:40 == 35
4/7/25 2:15 == 34.9	4/7/25 6:45 == 35.3	4/7/25 11:15 == 34.2	4/7/25 15:45 == 34.8
4/7/25 2:20 == 34.5	4/7/25 6:50 == 35.2	4/7/25 11:20 == 34.2	4/7/25 15:50 == 34.8
4/7/25 2:25 == 34.6	4/7/25 6:55 == 29.7	4/7/25 11:25 == 34.3	4/7/25 15:55 == 34.9
4/7/25 2:30 == 34.7	4/7/25 7:00 == 21.2	4/7/25 11:30 == 34.4	4/7/25 16:00 == 35
4/7/25 2:35 == 34.6	4/7/25 7:05 == 17.4	4/7/25 11:35 == 34.3	4/7/25 16:05 == 34.6
4/7/25 2:40 == 34.6	4/7/25 7:10 == 17.5	4/7/25 11:40 == 34.5	4/7/25 16:10 == 34.9
4/7/25 2:45 == 34.5	4/7/25 7:15 == 17.6	4/7/25 11:45 == 34.6	4/7/25 16:15 == 34.4
4/7/25 2:50 == 34.7	4/7/25 7:20 == 17.4	4/7/25 11:50 == 34.5	4/7/25 16:20 == 33.9
4/7/25 2:55 == 34.7	4/7/25 7:25 == 20.4	4/7/25 11:55 == 34.3	4/7/25 16:25 == 33.9
4/7/25 3:00 == 34.1	4/7/25 7:30 == 28.6	4/7/25 12:00 == 34.1	4/7/25 16:30 == 34.1
4/7/25 3:05 == 34.4	4/7/25 7:35 == 34.5	4/7/25 12:05 == 33.9	4/7/25 16:35 == 34.3
4/7/25 3:10 == 34.9	4/7/25 7:40 == 34.6	4/7/25 12:10 == 33.9	4/7/25 16:40 == 34.5
4/7/25 3:15 == 34.9	4/7/25 7:45 == 34.5	4/7/25 12:15 == 34	4/7/25 16:45 == 34.5
4/7/25 3:20 == 34.9	4/7/25 7:50 == 34.4	4/7/25 12:20 == 34	4/7/25 16:50 == 34.4
4/7/25 3:25 == 34.8	4/7/25 7:55 == 34.4	4/7/25 12:25 == 34	4/7/25 16:55 == 34.5
4/7/25 3:30 == 34.6	4/7/25 8:00 == 34.2	4/7/25 12:30 == 34.2	4/7/25 17:00 == 34.5
4/7/25 3:35 == 34.5	4/7/25 8:05 == 34.3	4/7/25 12:35 == 34.3	4/7/25 17:05 == 34.5
4/7/25 3:40 == 34.5	4/7/25 8:10 == 34.3	4/7/25 12:40 == 34.1	4/7/25 17:10 == 34.6
4/7/25 3:45 == 34.7	4/7/25 8:15 == 33.8	4/7/25 12:45 == 33.8	4/7/25 17:15 == 34.7
4/7/25 3:50 == 34.7	4/7/25 8:20 == 34	4/7/25 12:50 == 33.8	4/7/25 17:20 == 34.7
4/7/25 3:55 == 34.4	4/7/25 8:25 == 34	4/7/25 12:55 == 33.7	4/7/25 17:25 == 34.7
4/7/25 4:00 == 34.1	4/7/25 8:30 == 33.9	4/7/25 13:00 == 33.5	4/7/25 17:30 == 34.8
4/7/25 4:05 == 34.3	4/7/25 8:35 == 34	4/7/25 13:05 == 33.6	4/7/25 17:35 == 34.9
4/7/25 4:10 == 34.7	4/7/25 8:40 == 34	4/7/25 13:10 == 33.7	4/7/25 17:40 == 35
4/7/25 4:15 == 34.7	4/7/25 8:45 == 34	4/7/25 13:15 == 33.7	4/7/25 17:45 == 34.9
4/7/25 4:20 == 34.5	4/7/25 8:50 == 34.1	4/7/25 13:20 == 33.9	4/7/25 17:50 == 34.7
4/7/25 4:25 == 34.5	4/7/25 8:55 == 34	4/7/25 13:25 == 34.3	4/7/25 17:55 == 34.4

Pumpback Station Discharge (0364)

4/7/25 18:00 == 34.1	4/7/25 22:30 == 34.5	4/8/25 3:00 == 48	4/8/25 7:30 == 35
4/7/25 18:05 == 34.1	4/7/25 22:35 == 34.4	4/8/25 3:05 == 48.1	4/8/25 7:35 == 35
4/7/25 18:10 == 34.3	4/7/25 22:40 == 34.3	4/8/25 3:10 == 46.2	4/8/25 7:40 == 35.1
4/7/25 18:15 == 34.4	4/7/25 22:45 == 34.3	4/8/25 3:15 == 37.9	4/8/25 7:45 == 34.9
4/7/25 18:20 == 34.5	4/7/25 22:50 == 34.2	4/8/25 3:20 == 34.2	4/8/25 7:50 == 35
4/7/25 18:25 == 34.4	4/7/25 22:55 == 34.2	4/8/25 3:25 == 34.3	4/8/25 7:55 == 34.9
4/7/25 18:30 == 34.2	4/7/25 23:00 == 34.1	4/8/25 3:30 == 34.2	4/8/25 8:00 == 34.9
4/7/25 18:35 == 33.9	4/7/25 23:05 == 34.1	4/8/25 3:35 == 34.1	4/8/25 8:05 == 34.9
4/7/25 18:40 == 33.9	4/7/25 23:10 == 34	4/8/25 3:40 == 34.1	4/8/25 8:10 == 34.7
4/7/25 18:45 == 33.7	4/7/25 23:15 == 33.9	4/8/25 3:45 == 34.1	4/8/25 8:15 == 34.3
4/7/25 18:50 == 33.7	4/7/25 23:20 == 33.9	4/8/25 3:50 == 34	4/8/25 8:20 == 34.4
4/7/25 18:55 == 34	4/7/25 23:25 == 34	4/8/25 3:55 == 34	4/8/25 8:25 == 34.3
4/7/25 19:00 == 34.3	4/7/25 23:30 == 34	4/8/25 4:00 == 34.1	4/8/25 8:30 == 34.1
4/7/25 19:05 == 34.2	4/7/25 23:35 == 33.8	4/8/25 4:05 == 34.1	4/8/25 8:35 == 34
4/7/25 19:10 == 34.3	4/7/25 23:40 == 33.7	4/8/25 4:10 == 34.1	4/8/25 8:40 == 34
4/7/25 19:15 == 34.3	4/7/25 23:45 == 33.8	4/8/25 4:15 == 34.1	4/8/25 8:45 == 41.5
4/7/25 19:20 == 34.2	4/7/25 23:50 == 33.7	4/8/25 4:20 == 34.1	4/8/25 8:50 == 47.9
4/7/25 19:25 == 34.2	4/7/25 23:55 == 33.7	4/8/25 4:25 == 34.2	4/8/25 8:55 == 48
4/7/25 19:30 == 34.2	4/8/25 0:00 == 33.6	4/8/25 4:30 == 34.2	4/8/25 9:00 == 47.9
4/7/25 19:35 == 34.2	4/8/25 0:05 == 33.5	4/8/25 4:35 == 34	4/8/25 9:05 == 47.9
4/7/25 19:40 == 34.4	4/8/25 0:10 == 33.8	4/8/25 4:40 == 34	4/8/25 9:10 == 48
4/7/25 19:45 == 34.4	4/8/25 0:15 == 33.8	4/8/25 4:45 == 34.1	4/8/25 9:15 == 48
4/7/25 19:50 == 34.4	4/8/25 0:20 == 33.6	4/8/25 4:50 == 34.1	4/8/25 9:20 == 48
4/7/25 19:55 == 34.5	4/8/25 0:25 == 33.9	4/8/25 4:55 == 34.1	4/8/25 9:25 == 46.1
4/7/25 20:00 == 34.4	4/8/25 0:30 == 33.9	4/8/25 5:00 == 34.1	4/8/25 9:30 == 39.7
4/7/25 20:05 == 34.1	4/8/25 0:35 == 33.9	4/8/25 5:05 == 34.1	4/8/25 9:35 == 34.4
4/7/25 20:10 == 33.9	4/8/25 0:40 == 34	4/8/25 5:10 == 34.2	4/8/25 9:40 == 34.4
4/7/25 20:15 == 33.7	4/8/25 0:45 == 34	4/8/25 5:15 == 34.1	4/8/25 9:45 == 34.3
4/7/25 20:20 == 33.6	4/8/25 0:50 == 33.9	4/8/25 5:20 == 34.1	4/8/25 9:50 == 34.4
4/7/25 20:25 == 33.7	4/8/25 0:55 == 34	4/8/25 5:25 == 33.9	4/8/25 9:55 == 34.3
4/7/25 20:30 == 33.7	4/8/25 1:00 == 34	4/8/25 5:30 == 34	4/8/25 10:00 == 34.2
4/7/25 20:35 == 33.9	4/8/25 1:05 == 34	4/8/25 5:35 == 34.1	4/8/25 10:05 == 34.4
4/7/25 20:40 == 33.9	4/8/25 1:10 == 34.1	4/8/25 5:40 == 34.1	4/8/25 10:10 == 34.5
4/7/25 20:45 == 33.9	4/8/25 1:15 == 34.2	4/8/25 5:45 == 34	4/8/25 10:15 == 34.6
4/7/25 20:50 == 34	4/8/25 1:20 == 34.3	4/8/25 5:50 == 34	4/8/25 10:20 == 34.6
4/7/25 20:55 == 34	4/8/25 1:25 == 34.2	4/8/25 5:55 == 34	4/8/25 10:25 == 34.7
4/7/25 21:00 == 33.8	4/8/25 1:30 == 33.9	4/8/25 6:00 == 34	4/8/25 10:30 == 34.6
4/7/25 21:05 == 33.9	4/8/25 1:35 == 33.9	4/8/25 6:05 == 34.1	4/8/25 10:35 == 34.8
4/7/25 21:10 == 34.2	4/8/25 1:40 == 34	4/8/25 6:10 == 34.2	4/8/25 10:40 == 35.3
4/7/25 21:15 == 34.2	4/8/25 1:45 == 33.9	4/8/25 6:15 == 34.3	4/8/25 10:45 == 35.3
4/7/25 21:20 == 34.3	4/8/25 1:50 == 34.1	4/8/25 6:20 == 34.2	4/8/25 10:50 == 35.3
4/7/25 21:25 == 34.5	4/8/25 1:55 == 34.4	4/8/25 6:25 == 34.4	4/8/25 10:55 == 35.2
4/7/25 21:30 == 34.3	4/8/25 2:00 == 34.7	4/8/25 6:30 == 34.6	4/8/25 11:00 == 35.2
4/7/25 21:35 == 34.3	4/8/25 2:05 == 34.8	4/8/25 6:35 == 34.5	4/8/25 11:05 == 35.2
4/7/25 21:40 == 34.4	4/8/25 2:10 == 34.8	4/8/25 6:40 == 34.4	4/8/25 11:10 == 35.2
4/7/25 21:45 == 34.3	4/8/25 2:15 == 34.7	4/8/25 6:45 == 34.4	4/8/25 11:15 == 35.2
4/7/25 21:50 == 34.4	4/8/25 2:20 == 34.5	4/8/25 6:50 == 34.6	4/8/25 11:20 == 35.1
4/7/25 21:55 == 34.3	4/8/25 2:25 == 34.8	4/8/25 6:55 == 34.7	4/8/25 11:25 == 35.2
4/7/25 22:00 == 34.4	4/8/25 2:30 == 43.5	4/8/25 7:00 == 34.7	4/8/25 11:30 == 35.3
4/7/25 22:05 == 34.5	4/8/25 2:35 == 47.5	4/8/25 7:05 == 34.7	4/8/25 11:35 == 35
4/7/25 22:10 == 34.5	4/8/25 2:40 == 48.1	4/8/25 7:10 == 35.1	4/8/25 11:40 == 35.2
4/7/25 22:15 == 34.3	4/8/25 2:45 == 48.1	4/8/25 7:15 == 35	4/8/25 11:45 == 35.3
4/7/25 22:20 == 34.4	4/8/25 2:50 == 48	4/8/25 7:20 == 34.9	4/8/25 11:50 == 35
4/7/25 22:25 == 34.5	4/8/25 2:55 == 47.8	4/8/25 7:25 == 34.9	4/8/25 11:55 == 34.9

Pumpback Station Discharge (0364)

4/8/25 12:00 == 34.4	4/8/25 16:30 == 34.7	4/8/25 21:00 == 33.9	4/9/25 1:30 == 33.6
4/8/25 12:05 == 34.4	4/8/25 16:35 == 34.9	4/8/25 21:05 == 34	4/9/25 1:35 == 33.6
4/8/25 12:10 == 34.8	4/8/25 16:40 == 35	4/8/25 21:10 == 34.2	4/9/25 1:40 == 33.6
4/8/25 12:15 == 34.8	4/8/25 16:45 == 35.1	4/8/25 21:15 == 34.2	4/9/25 1:45 == 33.7
4/8/25 12:20 == 34.9	4/8/25 16:50 == 35.1	4/8/25 21:20 == 34.1	4/9/25 1:50 == 33.7
4/8/25 12:25 == 35.1	4/8/25 16:55 == 35.1	4/8/25 21:25 == 34.1	4/9/25 1:55 == 34.1
4/8/25 12:30 == 34.8	4/8/25 17:00 == 34.9	4/8/25 21:30 == 40.5	4/9/25 2:00 == 34.2
4/8/25 12:35 == 35.1	4/8/25 17:05 == 34.7	4/8/25 21:35 == 46.5	4/9/25 2:05 == 34.1
4/8/25 12:40 == 35.1	4/8/25 17:10 == 34.5	4/8/25 21:40 == 47.9	4/9/25 2:10 == 34.2
4/8/25 12:45 == 35.1	4/8/25 17:15 == 34.3	4/8/25 21:45 == 48	4/9/25 2:15 == 34.2
4/8/25 12:50 == 34.8	4/8/25 17:20 == 34.4	4/8/25 21:50 == 48.1	4/9/25 2:20 == 34.2
4/8/25 12:55 == 35.1	4/8/25 17:25 == 34.6	4/8/25 21:55 == 48.1	4/9/25 2:25 == 34.3
4/8/25 13:00 == 35.3	4/8/25 17:30 == 34.8	4/8/25 22:00 == 48	4/9/25 2:30 == 40.8
4/8/25 13:05 == 35.3	4/8/25 17:35 == 35.1	4/8/25 22:05 == 47.9	4/9/25 2:35 == 46.7
4/8/25 13:10 == 35.4	4/8/25 17:40 == 35.2	4/8/25 22:10 == 46.5	4/9/25 2:40 == 48
4/8/25 13:15 == 35.3	4/8/25 17:45 == 35.3	4/8/25 22:15 == 40.7	4/9/25 2:45 == 47.7
4/8/25 13:20 == 35.1	4/8/25 17:50 == 35.3	4/8/25 22:20 == 33.9	4/9/25 2:50 == 47.8
4/8/25 13:25 == 35.6	4/8/25 17:55 == 35.5	4/8/25 22:25 == 34.2	4/9/25 2:55 == 47.7
4/8/25 13:30 == 35.3	4/8/25 18:00 == 35.2	4/8/25 22:30 == 34	4/9/25 3:00 == 47.6
4/8/25 13:35 == 35	4/8/25 18:05 == 35.2	4/8/25 22:35 == 34.1	4/9/25 3:05 == 48
4/8/25 13:40 == 35.3	4/8/25 18:10 == 35.3	4/8/25 22:40 == 34.2	4/9/25 3:10 == 46.9
4/8/25 13:45 == 35.5	4/8/25 18:15 == 34.8	4/8/25 22:45 == 33.9	4/9/25 3:15 == 41.2
4/8/25 13:50 == 35.4	4/8/25 18:20 == 35	4/8/25 22:50 == 33.9	4/9/25 3:20 == 33.9
4/8/25 13:55 == 35.5	4/8/25 18:25 == 34.8	4/8/25 22:55 == 33.9	4/9/25 3:25 == 33.8
4/8/25 14:00 == 35.4	4/8/25 18:30 == 34.6	4/8/25 23:00 == 33.8	4/9/25 3:30 == 33.7
4/8/25 14:05 == 35.2	4/8/25 18:35 == 34.3	4/8/25 23:05 == 33.8	4/9/25 3:35 == 33.7
4/8/25 14:10 == 35.3	4/8/25 18:40 == 34.2	4/8/25 23:10 == 33.9	4/9/25 3:40 == 33.9
4/8/25 14:15 == 35.5	4/8/25 18:45 == 41.6	4/8/25 23:15 == 33.9	4/9/25 3:45 == 33.8
4/8/25 14:20 == 35.6	4/8/25 18:50 == 47.1	4/8/25 23:20 == 33.7	4/9/25 3:50 == 33.8
4/8/25 14:25 == 35.7	4/8/25 18:55 == 48.1	4/8/25 23:25 == 33.8	4/9/25 3:55 == 33.8
4/8/25 14:30 == 35.7	4/8/25 19:00 == 48	4/8/25 23:30 == 33.6	4/9/25 4:00 == 33.8
4/8/25 14:35 == 35.6	4/8/25 19:05 == 47.9	4/8/25 23:35 == 33.6	4/9/25 4:05 == 33.9
4/8/25 14:40 == 35.4	4/8/25 19:10 == 47.7	4/8/25 23:40 == 33.5	4/9/25 4:10 == 34.1
4/8/25 14:45 == 35.3	4/8/25 19:15 == 47.7	4/8/25 23:45 == 33.5	4/9/25 4:15 == 33.9
4/8/25 14:50 == 35.6	4/8/25 19:20 == 48	4/8/25 23:50 == 33.6	4/9/25 4:20 == 33.8
4/8/25 14:55 == 35.7	4/8/25 19:25 == 46.7	4/8/25 23:55 == 33.6	4/9/25 4:25 == 34.1
4/8/25 15:00 == 35.6	4/8/25 19:30 == 40.8	4/9/25 0:00 == 39.8	4/9/25 4:30 == 34
4/8/25 15:05 == 35.8	4/8/25 19:35 == 33.8	4/9/25 0:05 == 46.1	4/9/25 4:35 == 33.9
4/8/25 15:10 == 36.3	4/8/25 19:40 == 34	4/9/25 0:10 == 47.7	4/9/25 4:40 == 33.7
4/8/25 15:15 == 36	4/8/25 19:45 == 34.2	4/9/25 0:15 == 47.8	4/9/25 4:45 == 39.3
4/8/25 15:20 == 35.6	4/8/25 19:50 == 34.1	4/9/25 0:20 == 48	4/9/25 4:50 == 45.7
4/8/25 15:25 == 35.8	4/8/25 19:55 == 34.1	4/9/25 0:25 == 47.9	4/9/25 4:55 == 47.8
4/8/25 15:30 == 35.7	4/8/25 20:00 == 34.2	4/9/25 0:30 == 47.8	4/9/25 5:00 == 48
4/8/25 15:35 == 35.6	4/8/25 20:05 == 34.2	4/9/25 0:35 == 48	4/9/25 5:05 == 48.1
4/8/25 15:40 == 35.8	4/8/25 20:10 == 34.3	4/9/25 0:40 == 47.1	4/9/25 5:10 == 47.9
4/8/25 15:45 == 35.5	4/8/25 20:15 == 34.1	4/9/25 0:45 == 41.5	4/9/25 5:15 == 47.9
4/8/25 15:50 == 35.5	4/8/25 20:20 == 34.1	4/9/25 0:50 == 33.6	4/9/25 5:20 == 47.9
4/8/25 15:55 == 35.4	4/8/25 20:25 == 34.5	4/9/25 0:55 == 33.7	4/9/25 5:25 == 47.7
4/8/25 16:00 == 35.4	4/8/25 20:30 == 34.3	4/9/25 1:00 == 33.8	4/9/25 5:30 == 40.9
4/8/25 16:05 == 35.3	4/8/25 20:35 == 34.2	4/9/25 1:05 == 33.8	4/9/25 5:35 == 33.8
4/8/25 16:10 == 35.3	4/8/25 20:40 == 34.4	4/9/25 1:10 == 33.9	4/9/25 5:40 == 33.6
4/8/25 16:15 == 35.2	4/8/25 20:45 == 34.4	4/9/25 1:15 == 33.8	4/9/25 5:45 == 33.6
4/8/25 16:20 == 34.9	4/8/25 20:50 == 34.3	4/9/25 1:20 == 33.8	4/9/25 5:50 == 33.7
4/8/25 16:25 == 34.7	4/8/25 20:55 == 34.1	4/9/25 1:25 == 33.7	4/9/25 5:55 == 33.7

Pumpback Station Discharge (0364)

4/9/25 6:00 == 33.7	4/9/25 10:30 == 47.7	4/9/25 15:00 == 35.8	4/9/25 19:30 == 48
4/9/25 6:05 == 33.8	4/9/25 10:35 == 47.7	4/9/25 15:05 == 35.7	4/9/25 19:35 == 48
4/9/25 6:10 == 34	4/9/25 10:40 == 47.5	4/9/25 15:10 == 35.8	4/9/25 19:40 == 47.8
4/9/25 6:15 == 34.2	4/9/25 10:45 == 47.6	4/9/25 15:15 == 35.7	4/9/25 19:45 == 43.8
4/9/25 6:20 == 34.3	4/9/25 10:50 == 47.9	4/9/25 15:20 == 35.8	4/9/25 19:50 == 34.6
4/9/25 6:25 == 34.5	4/9/25 10:55 == 48	4/9/25 15:25 == 35.9	4/9/25 19:55 == 34.2
4/9/25 6:30 == 34.7	4/9/25 11:00 == 47.9	4/9/25 15:30 == 35.8	4/9/25 20:00 == 33.9
4/9/25 6:35 == 34.7	4/9/25 11:05 == 48.1	4/9/25 15:35 == 35.9	4/9/25 20:05 == 33.9
4/9/25 6:40 == 34.5	4/9/25 11:10 == 47.4	4/9/25 15:40 == 35.9	4/9/25 20:10 == 33.6
4/9/25 6:45 == 34.4	4/9/25 11:15 == 43.2	4/9/25 15:45 == 35.8	4/9/25 20:15 == 33.7
4/9/25 6:50 == 34.6	4/9/25 11:20 == 35.5	4/9/25 15:50 == 35.8	4/9/25 20:20 == 33.7
4/9/25 6:55 == 34.9	4/9/25 11:25 == 35.5	4/9/25 15:55 == 35.9	4/9/25 20:25 == 34
4/9/25 7:00 == 34.7	4/9/25 11:30 == 35.5	4/9/25 16:00 == 35.9	4/9/25 20:30 == 34.1
4/9/25 7:05 == 34.7	4/9/25 11:35 == 35.5	4/9/25 16:05 == 35.7	4/9/25 20:35 == 34.1
4/9/25 7:10 == 35.2	4/9/25 11:40 == 35.4	4/9/25 16:10 == 35.4	4/9/25 20:40 == 34.2
4/9/25 7:15 == 40.1	4/9/25 11:45 == 35.4	4/9/25 16:15 == 35	4/9/25 20:45 == 34.3
4/9/25 7:20 == 46.6	4/9/25 11:50 == 35.3	4/9/25 16:20 == 34.5	4/9/25 20:50 == 34.2
4/9/25 7:25 == 48	4/9/25 11:55 == 35.4	4/9/25 16:25 == 34.4	4/9/25 20:55 == 33.9
4/9/25 7:30 == 47.9	4/9/25 12:00 == 34.6	4/9/25 16:30 == 37	4/9/25 21:00 == 37.7
4/9/25 7:35 == 48	4/9/25 12:05 == 34.8	4/9/25 16:35 == 47	4/9/25 21:05 == 44.6
4/9/25 7:40 == 48	4/9/25 12:10 == 35	4/9/25 16:40 == 47.8	4/9/25 21:10 == 47.5
4/9/25 7:45 == 48	4/9/25 12:15 == 34.6	4/9/25 16:45 == 48	4/9/25 21:15 == 47.5
4/9/25 7:50 == 48	4/9/25 12:20 == 34.5	4/9/25 16:50 == 48	4/9/25 21:20 == 47.9
4/9/25 7:55 == 48	4/9/25 12:25 == 34.6	4/9/25 16:55 == 47.9	4/9/25 21:25 == 48
4/9/25 8:00 == 41.8	4/9/25 12:30 == 34.6	4/9/25 17:00 == 48.1	4/9/25 21:30 == 48.1
4/9/25 8:05 == 35.6	4/9/25 12:35 == 34.7	4/9/25 17:05 == 48.1	4/9/25 21:35 == 48
4/9/25 8:10 == 34.9	4/9/25 12:40 == 34.7	4/9/25 17:10 == 47.6	4/9/25 21:40 == 47.6
4/9/25 8:15 == 34.6	4/9/25 12:45 == 34.8	4/9/25 17:15 == 42.7	4/9/25 21:45 == 44.4
4/9/25 8:20 == 34.6	4/9/25 12:50 == 34.8	4/9/25 17:20 == 35	4/9/25 21:50 == 33.9
4/9/25 8:25 == 34.7	4/9/25 12:55 == 34.7	4/9/25 17:25 == 34.3	4/9/25 21:55 == 34.1
4/9/25 8:30 == 34.5	4/9/25 13:00 == 34.7	4/9/25 17:30 == 34.1	4/9/25 22:00 == 34.1
4/9/25 8:35 == 34.3	4/9/25 13:05 == 34.8	4/9/25 17:35 == 34.1	4/9/25 22:05 == 34.1
4/9/25 8:40 == 34.3	4/9/25 13:10 == 34.9	4/9/25 17:40 == 34.1	4/9/25 22:10 == 34.1
4/9/25 8:45 == 34.2	4/9/25 13:15 == 39.3	4/9/25 17:45 == 34	4/9/25 22:15 == 33.8
4/9/25 8:50 == 34.1	4/9/25 13:20 == 45.9	4/9/25 17:50 == 34.2	4/9/25 22:20 == 33.8
4/9/25 8:55 == 33.7	4/9/25 13:25 == 47.8	4/9/25 17:55 == 34.1	4/9/25 22:25 == 33.6
4/9/25 9:00 == 33.7	4/9/25 13:30 == 47.5	4/9/25 18:00 == 34	4/9/25 22:30 == 33.6
4/9/25 9:05 == 33.9	4/9/25 13:35 == 47.9	4/9/25 18:05 == 34	4/9/25 22:35 == 33.8
4/9/25 9:10 == 34	4/9/25 13:40 == 47.9	4/9/25 18:10 == 34	4/9/25 22:40 == 33.9
4/9/25 9:15 == 34.1	4/9/25 13:45 == 47.7	4/9/25 18:15 == 33.9	4/9/25 22:45 == 33.7
4/9/25 9:20 == 34.4	4/9/25 13:50 == 47.9	4/9/25 18:20 == 33.9	4/9/25 22:50 == 33.6
4/9/25 9:25 == 34.4	4/9/25 13:55 == 47.4	4/9/25 18:25 == 33.8	4/9/25 22:55 == 33.7
4/9/25 9:30 == 34.2	4/9/25 14:00 == 43.9	4/9/25 18:30 == 33.7	4/9/25 23:00 == 33.6
4/9/25 9:35 == 34.4	4/9/25 14:05 == 35.8	4/9/25 18:35 == 33.8	4/9/25 23:05 == 33.8
4/9/25 9:40 == 34.6	4/9/25 14:10 == 36	4/9/25 18:40 == 33.8	4/9/25 23:10 == 33.8
4/9/25 9:45 == 34.6	4/9/25 14:15 == 35.7	4/9/25 18:45 == 33.8	4/9/25 23:15 == 37.8
4/9/25 9:50 == 34.6	4/9/25 14:20 == 35.3	4/9/25 18:50 == 33.7	4/9/25 23:20 == 44.4
4/9/25 9:55 == 34.7	4/9/25 14:25 == 35.3	4/9/25 18:55 == 33.7	4/9/25 23:25 == 47.7
4/9/25 10:00 == 34.4	4/9/25 14:30 == 34.7	4/9/25 19:00 == 34	4/9/25 23:30 == 47.7
4/9/25 10:05 == 34.5	4/9/25 14:35 == 34.8	4/9/25 19:05 == 34	4/9/25 23:35 == 47.4
4/9/25 10:10 == 34.7	4/9/25 14:40 == 35.4	4/9/25 19:10 == 33.9	4/9/25 23:40 == 47.7
4/9/25 10:15 == 40	4/9/25 14:45 == 35.2	4/9/25 19:15 == 35.8	4/9/25 23:45 == 48
4/9/25 10:20 == 46	4/9/25 14:50 == 35.6	4/9/25 19:20 == 46.9	4/9/25 23:50 == 48.1
4/9/25 10:25 == 47.6	4/9/25 14:55 == 35.7	4/9/25 19:25 == 48.1	4/9/25 23:55 == 48

Pumpback Station Discharge (0364)

4/10/25 0:00 == 43.9	4/10/25 4:30 == 47.8	4/10/25 9:00 == 34	4/10/25 13:30 == 33.8
4/10/25 0:05 == 34.6	4/10/25 4:35 == 48	4/10/25 9:05 == 33.9	4/10/25 13:35 == 34
4/10/25 0:10 == 33.5	4/10/25 4:40 == 47.9	4/10/25 9:10 == 34	4/10/25 13:40 == 34
4/10/25 0:15 == 33.4	4/10/25 4:45 == 43.2	4/10/25 9:15 == 34.1	4/10/25 13:45 == 34.3
4/10/25 0:20 == 33.4	4/10/25 4:50 == 36.1	4/10/25 9:20 == 34	4/10/25 13:50 == 34.3
4/10/25 0:25 == 33.5	4/10/25 4:55 == 33.7	4/10/25 9:25 == 34	4/10/25 13:55 == 34
4/10/25 0:30 == 33.7	4/10/25 5:00 == 33.8	4/10/25 9:30 == 33.9	4/10/25 14:00 == 34.2
4/10/25 0:35 == 33.6	4/10/25 5:05 == 33.8	4/10/25 9:35 == 33.7	4/10/25 14:05 == 34.2
4/10/25 0:40 == 33.7	4/10/25 5:10 == 33.9	4/10/25 9:40 == 33.8	4/10/25 14:10 == 34.6
4/10/25 0:45 == 33.7	4/10/25 5:15 == 33.9	4/10/25 9:45 == 33.9	4/10/25 14:15 == 34.5
4/10/25 0:50 == 33.6	4/10/25 5:20 == 33.9	4/10/25 9:50 == 33.8	4/10/25 14:20 == 34.4
4/10/25 0:55 == 33.6	4/10/25 5:25 == 34	4/10/25 9:55 == 33.9	4/10/25 14:25 == 33.9
4/10/25 1:00 == 33.5	4/10/25 5:30 == 34.1	4/10/25 10:00 == 37.1	4/10/25 14:30 == 33.7
4/10/25 1:05 == 33.6	4/10/25 5:35 == 34.1	4/10/25 10:05 == 43.5	4/10/25 14:35 == 33.6
4/10/25 1:10 == 33.4	4/10/25 5:40 == 34.2	4/10/25 10:10 == 47.7	4/10/25 14:40 == 33.8
4/10/25 1:15 == 33.6	4/10/25 5:45 == 33.9	4/10/25 10:15 == 48.1	4/10/25 14:45 == 34
4/10/25 1:20 == 33.7	4/10/25 5:50 == 33.8	4/10/25 10:20 == 48	4/10/25 14:50 == 34
4/10/25 1:25 == 33.8	4/10/25 5:55 == 33.8	4/10/25 10:25 == 47.9	4/10/25 14:55 == 34
4/10/25 1:30 == 35.6	4/10/25 6:00 == 34	4/10/25 10:30 == 47.6	4/10/25 15:00 == 36.9
4/10/25 1:35 == 44.3	4/10/25 6:05 == 34.1	4/10/25 10:35 == 48	4/10/25 15:05 == 43.3
4/10/25 1:40 == 47.9	4/10/25 6:10 == 34.1	4/10/25 10:40 == 47.4	4/10/25 15:10 == 47.6
4/10/25 1:45 == 48.2	4/10/25 6:15 == 34.3	4/10/25 10:45 == 45.6	4/10/25 15:15 == 47.9
4/10/25 1:50 == 48.1	4/10/25 6:20 == 34.1	4/10/25 10:50 == 34.8	4/10/25 15:20 == 47.9
4/10/25 1:55 == 47.6	4/10/25 6:25 == 34.4	4/10/25 10:55 == 34.4	4/10/25 15:25 == 47.9
4/10/25 2:00 == 47.6	4/10/25 6:30 == 36.3	4/10/25 11:00 == 34.4	4/10/25 15:30 == 47.9
4/10/25 2:05 == 47.9	4/10/25 6:35 == 45	4/10/25 11:05 == 34.5	4/10/25 15:35 == 47.8
4/10/25 2:10 == 48	4/10/25 6:40 == 47.8	4/10/25 11:10 == 35	4/10/25 15:40 == 47.7
4/10/25 2:15 == 43.2	4/10/25 6:45 == 48	4/10/25 11:15 == 35	4/10/25 15:45 == 45.4
4/10/25 2:20 == 35.8	4/10/25 6:50 == 48.1	4/10/25 11:20 == 34.8	4/10/25 15:50 == 36.3
4/10/25 2:25 == 34.1	4/10/25 6:55 == 47.7	4/10/25 11:25 == 35	4/10/25 15:55 == 34.3
4/10/25 2:30 == 34.2	4/10/25 7:00 == 47.8	4/10/25 11:30 == 34.7	4/10/25 16:00 == 34.2
4/10/25 2:35 == 34.3	4/10/25 7:05 == 48	4/10/25 11:35 == 34.6	4/10/25 16:05 == 34.4
4/10/25 2:40 == 34.3	4/10/25 7:10 == 47.7	4/10/25 11:40 == 34.7	4/10/25 16:10 == 34.8
4/10/25 2:45 == 34.3	4/10/25 7:15 == 43.1	4/10/25 11:45 == 34.6	4/10/25 16:15 == 34.3
4/10/25 2:50 == 34.2	4/10/25 7:20 == 36.6	4/10/25 11:50 == 34.5	4/10/25 16:20 == 34.2
4/10/25 2:55 == 34	4/10/25 7:25 == 34.1	4/10/25 11:55 == 34.3	4/10/25 16:25 == 34.2
4/10/25 3:00 == 33.5	4/10/25 7:30 == 34.1	4/10/25 12:00 == 34	4/10/25 16:30 == 33.9
4/10/25 3:05 == 33.7	4/10/25 7:35 == 34.1	4/10/25 12:05 == 33.9	4/10/25 16:35 == 34
4/10/25 3:10 == 34	4/10/25 7:40 == 34.1	4/10/25 12:10 == 33.9	4/10/25 16:40 == 33.8
4/10/25 3:15 == 33.9	4/10/25 7:45 == 34.1	4/10/25 12:15 == 33.8	4/10/25 16:45 == 33.7
4/10/25 3:20 == 33.9	4/10/25 7:50 == 34.2	4/10/25 12:20 == 33.8	4/10/25 16:50 == 33.6
4/10/25 3:25 == 33.8	4/10/25 7:55 == 34.5	4/10/25 12:25 == 33.8	4/10/25 16:55 == 33.8
4/10/25 3:30 == 33.9	4/10/25 8:00 == 34.4	4/10/25 12:30 == 36.4	4/10/25 17:00 == 34
4/10/25 3:35 == 34	4/10/25 8:05 == 34.6	4/10/25 12:35 == 42.9	4/10/25 17:05 == 33.9
4/10/25 3:40 == 33.9	4/10/25 8:10 == 34.6	4/10/25 12:40 == 47.7	4/10/25 17:10 == 34.5
4/10/25 3:45 == 34.1	4/10/25 8:15 == 34.1	4/10/25 12:45 == 47.9	4/10/25 17:15 == 34.6
4/10/25 3:50 == 33.9	4/10/25 8:20 == 34.3	4/10/25 12:50 == 48	4/10/25 17:20 == 34.4
4/10/25 3:55 == 33.9	4/10/25 8:25 == 34.3	4/10/25 12:55 == 48	4/10/25 17:25 == 34.4
4/10/25 4:00 == 36.2	4/10/25 8:30 == 33.9	4/10/25 13:00 == 47.8	4/10/25 17:30 == 34.3
4/10/25 4:05 == 44.7	4/10/25 8:35 == 33.8	4/10/25 13:05 == 48	4/10/25 17:35 == 34.3
4/10/25 4:10 == 47.6	4/10/25 8:40 == 33.4	4/10/25 13:10 == 48	4/10/25 17:40 == 34.5
4/10/25 4:15 == 48	4/10/25 8:45 == 33.6	4/10/25 13:15 == 45.8	4/10/25 17:45 == 34.4
4/10/25 4:20 == 48.1	4/10/25 8:50 == 33.8	4/10/25 13:20 == 35	4/10/25 17:50 == 34.3
4/10/25 4:25 == 47.7	4/10/25 8:55 == 33.9	4/10/25 13:25 == 34.1	4/10/25 17:55 == 34.3

Pumpback Station Discharge (0364)

4/10/25 18:00 == 34.1	4/10/25 22:30 == 34	4/11/25 3:00 == 33.8	4/11/25 7:30 == 34.5
4/10/25 18:05 == 34	4/10/25 22:35 == 34	4/11/25 3:05 == 33.7	4/11/25 7:35 == 34.4
4/10/25 18:10 == 34	4/10/25 22:40 == 34	4/11/25 3:10 == 34	4/11/25 7:40 == 34.3
4/10/25 18:15 == 33.9	4/10/25 22:45 == 34	4/11/25 3:15 == 34.2	4/11/25 7:45 == 34.3
4/10/25 18:20 == 33.8	4/10/25 22:50 == 34	4/11/25 3:20 == 34.2	4/11/25 7:50 == 34.3
4/10/25 18:25 == 33.6	4/10/25 22:55 == 34.1	4/11/25 3:25 == 34.1	4/11/25 7:55 == 34.5
4/10/25 18:30 == 35	4/10/25 23:00 == 34.1	4/11/25 3:30 == 34.1	4/11/25 8:00 == 34.5
4/10/25 18:35 == 43.8	4/10/25 23:05 == 34.1	4/11/25 3:35 == 34.2	4/11/25 8:05 == 34.3
4/10/25 18:40 == 47.9	4/10/25 23:10 == 34.1	4/11/25 3:40 == 34.3	4/11/25 8:10 == 34.3
4/10/25 18:45 == 47.9	4/10/25 23:15 == 34.2	4/11/25 3:45 == 34.3	4/11/25 8:15 == 34
4/10/25 18:50 == 47.8	4/10/25 23:20 == 34.2	4/11/25 3:50 == 34.2	4/11/25 8:20 == 34.1
4/10/25 18:55 == 47.8	4/10/25 23:25 == 34.2	4/11/25 3:55 == 34.1	4/11/25 8:25 == 34.1
4/10/25 19:00 == 47.7	4/10/25 23:30 == 34	4/11/25 4:00 == 34	4/11/25 8:30 == 33.9
4/10/25 19:05 == 48	4/10/25 23:35 == 33.7	4/11/25 4:05 == 34.1	4/11/25 8:35 == 34
4/10/25 19:10 == 48.2	4/10/25 23:40 == 33.6	4/11/25 4:10 == 34.1	4/11/25 8:40 == 34.1
4/10/25 19:15 == 46.5	4/10/25 23:45 == 33.6	4/11/25 4:15 == 35.8	4/11/25 8:45 == 34.2
4/10/25 19:20 == 36	4/10/25 23:50 == 33.7	4/11/25 4:20 == 41.6	4/11/25 8:50 == 34.2
4/10/25 19:25 == 34	4/10/25 23:55 == 33.7	4/11/25 4:25 == 47.9	4/11/25 8:55 == 34.3
4/10/25 19:30 == 33.8	4/11/25 0:00 == 33.7	4/11/25 4:30 == 48.1	4/11/25 9:00 == 34.3
4/10/25 19:35 == 33.8	4/11/25 0:05 == 33.8	4/11/25 4:35 == 47.9	4/11/25 9:05 == 34.2
4/10/25 19:40 == 34.1	4/11/25 0:10 == 33.7	4/11/25 4:40 == 47.8	4/11/25 9:10 == 34.2
4/10/25 19:45 == 34.2	4/11/25 0:15 == 33.8	4/11/25 4:45 == 47.9	4/11/25 9:15 == 34.3
4/10/25 19:50 == 34.2	4/11/25 0:20 == 33.8	4/11/25 4:50 == 47.9	4/11/25 9:20 == 34.2
4/10/25 19:55 == 34.1	4/11/25 0:25 == 34.1	4/11/25 4:55 == 47.6	4/11/25 9:25 == 34.1
4/10/25 20:00 == 34.1	4/11/25 0:30 == 34.1	4/11/25 5:00 == 47.4	4/11/25 9:30 == 35.3
4/10/25 20:05 == 34.1	4/11/25 0:35 == 43.8	4/11/25 5:05 == 37	4/11/25 9:35 == 40.8
4/10/25 20:10 == 34	4/11/25 0:40 == 47.6	4/11/25 5:10 == 34.1	4/11/25 9:40 == 47.6
4/10/25 20:15 == 34.1	4/11/25 0:45 == 47.9	4/11/25 5:15 == 34	4/11/25 9:45 == 47.5
4/10/25 20:20 == 34	4/11/25 0:50 == 48	4/11/25 5:20 == 34	4/11/25 9:50 == 47.9
4/10/25 20:25 == 34.1	4/11/25 0:55 == 48.1	4/11/25 5:25 == 34.1	4/11/25 9:55 == 48.1
4/10/25 20:30 == 34.4	4/11/25 1:00 == 48.1	4/11/25 5:30 == 34.1	4/11/25 10:00 == 48
4/10/25 20:35 == 34.3	4/11/25 1:05 == 48.2	4/11/25 5:35 == 34.3	4/11/25 10:05 == 47.9
4/10/25 20:40 == 34.4	4/11/25 1:10 == 48	4/11/25 5:40 == 34.3	4/11/25 10:10 == 48.1
4/10/25 20:45 == 34.7	4/11/25 1:15 == 47.9	4/11/25 5:45 == 34.1	4/11/25 10:15 == 47.8
4/10/25 20:50 == 34.5	4/11/25 1:20 == 48	4/11/25 5:50 == 34.2	4/11/25 10:20 == 36.9
4/10/25 20:55 == 34.4	4/11/25 1:25 == 47.9	4/11/25 5:55 == 34.4	4/11/25 10:25 == 34.4
4/10/25 21:00 == 35.5	4/11/25 1:30 == 45	4/11/25 6:00 == 34.4	4/11/25 10:30 == 34.4
4/10/25 21:05 == 42.9	4/11/25 1:35 == 38.4	4/11/25 6:05 == 34.5	4/11/25 10:35 == 34.6
4/10/25 21:10 == 47.4	4/11/25 1:40 == 33.9	4/11/25 6:10 == 34.4	4/11/25 10:40 == 35
4/10/25 21:15 == 47.8	4/11/25 1:45 == 33.7	4/11/25 6:15 == 34.4	4/11/25 10:45 == 34.8
4/10/25 21:20 == 47.8	4/11/25 1:50 == 33.8	4/11/25 6:20 == 34.2	4/11/25 10:50 == 34.7
4/10/25 21:25 == 48.1	4/11/25 1:55 == 34.3	4/11/25 6:25 == 34.3	4/11/25 10:55 == 34.9
4/10/25 21:30 == 47.8	4/11/25 2:00 == 34.5	4/11/25 6:30 == 34.3	4/11/25 11:00 == 35
4/10/25 21:35 == 47.8	4/11/25 2:05 == 34.4	4/11/25 6:35 == 34.2	4/11/25 11:05 == 35
4/10/25 21:40 == 48	4/11/25 2:10 == 34.5	4/11/25 6:40 == 34.2	4/11/25 11:10 == 35.3
4/10/25 21:45 == 46.9	4/11/25 2:15 == 34.6	4/11/25 6:45 == 34.3	4/11/25 11:15 == 35
4/10/25 21:50 == 36.3	4/11/25 2:20 == 34.5	4/11/25 6:50 == 34.4	4/11/25 11:20 == 34.9
4/10/25 21:55 == 34.5	4/11/25 2:25 == 34.6	4/11/25 6:55 == 34.5	4/11/25 11:25 == 34.7
4/10/25 22:00 == 34.5	4/11/25 2:30 == 34.6	4/11/25 7:00 == 34.6	4/11/25 11:30 == 34.5
4/10/25 22:05 == 34.3	4/11/25 2:35 == 34.4	4/11/25 7:05 == 34.6	4/11/25 11:35 == 34.4
4/10/25 22:10 == 34.1	4/11/25 2:40 == 34.4	4/11/25 7:10 == 35	4/11/25 11:40 == 34.5
4/10/25 22:15 == 34	4/11/25 2:45 == 34.1	4/11/25 7:15 == 35.3	4/11/25 11:45 == 34.5
4/10/25 22:20 == 34	4/11/25 2:50 == 34.2	4/11/25 7:20 == 35	4/11/25 11:50 == 34.4
4/10/25 22:25 == 34	4/11/25 2:55 == 33.9	4/11/25 7:25 == 34.9	4/11/25 11:55 == 34.3

Pumpback Station Discharge (0364)

4/11/25 12:00 == 33.8	4/11/25 16:30 == 47.9	4/11/25 21:00 == 34.5	4/12/25 1:30 == 33.9
4/11/25 12:05 == 33.8	4/11/25 16:35 == 47.9	4/11/25 21:05 == 34.4	4/12/25 1:35 == 34.1
4/11/25 12:10 == 33.8	4/11/25 16:40 == 48	4/11/25 21:10 == 34.4	4/12/25 1:40 == 34.1
4/11/25 12:15 == 33.5	4/11/25 16:45 == 46.7	4/11/25 21:15 == 34.3	4/12/25 1:45 == 33.9
4/11/25 12:20 == 33.5	4/11/25 16:50 == 39.9	4/11/25 21:20 == 34	4/12/25 1:50 == 34
4/11/25 12:25 == 33.6	4/11/25 16:55 == 33.8	4/11/25 21:25 == 34.3	4/12/25 1:55 == 34.6
4/11/25 12:30 == 33.5	4/11/25 17:00 == 33.8	4/11/25 21:30 == 34.3	4/12/25 2:00 == 34.5
4/11/25 12:35 == 33.6	4/11/25 17:05 == 33.7	4/11/25 21:35 == 34.3	4/12/25 2:05 == 34.5
4/11/25 12:40 == 33.6	4/11/25 17:10 == 33.9	4/11/25 21:40 == 34.5	4/12/25 2:10 == 34.7
4/11/25 12:45 == 33.8	4/11/25 17:15 == 34.3	4/11/25 21:45 == 34.5	4/12/25 2:15 == 34.6
4/11/25 12:50 == 40.7	4/11/25 17:20 == 34.3	4/11/25 21:50 == 34.5	4/12/25 2:20 == 34.2
4/11/25 12:55 == 47.6	4/11/25 17:25 == 34.4	4/11/25 21:55 == 34.8	4/12/25 2:25 == 34.2
4/11/25 13:00 == 47.9	4/11/25 17:30 == 34.3	4/11/25 22:00 == 34.8	4/12/25 2:30 == 34
4/11/25 13:05 == 48	4/11/25 17:35 == 34.3	4/11/25 22:05 == 34.5	4/12/25 2:35 == 34.1
4/11/25 13:10 == 48	4/11/25 17:40 == 34.4	4/11/25 22:10 == 34.3	4/12/25 2:40 == 34.3
4/11/25 13:15 == 48.2	4/11/25 17:45 == 34.1	4/11/25 22:15 == 34.4	4/12/25 2:45 == 34.4
4/11/25 13:20 == 47.5	4/11/25 17:50 == 34	4/11/25 22:20 == 34.1	4/12/25 2:50 == 34.5
4/11/25 13:25 == 47.3	4/11/25 17:55 == 33.9	4/11/25 22:25 == 34	4/12/25 2:55 == 34.3
4/11/25 13:30 == 47.7	4/11/25 18:00 == 33.6	4/11/25 22:30 == 33.9	4/12/25 3:00 == 34.2
4/11/25 13:35 == 37.6	4/11/25 18:05 == 33.9	4/11/25 22:35 == 33.9	4/12/25 3:05 == 34.2
4/11/25 13:40 == 34	4/11/25 18:10 == 34	4/11/25 22:40 == 34	4/12/25 3:10 == 34.4
4/11/25 13:45 == 34.1	4/11/25 18:15 == 33.9	4/11/25 22:45 == 33.7	4/12/25 3:15 == 34.6
4/11/25 13:50 == 34.2	4/11/25 18:20 == 33.9	4/11/25 22:50 == 33.9	4/12/25 3:20 == 34.5
4/11/25 13:55 == 34.2	4/11/25 18:25 == 34.1	4/11/25 22:55 == 34	4/12/25 3:25 == 34.4
4/11/25 14:00 == 34.3	4/11/25 18:30 == 34.1	4/11/25 23:00 == 34.2	4/12/25 3:30 == 34.4
4/11/25 14:05 == 34.4	4/11/25 18:35 == 34.2	4/11/25 23:05 == 34	4/12/25 3:35 == 34.2
4/11/25 14:10 == 34.5	4/11/25 18:40 == 34.3	4/11/25 23:10 == 34	4/12/25 3:40 == 34
4/11/25 14:15 == 34.5	4/11/25 18:45 == 34.3	4/11/25 23:15 == 34	4/12/25 3:45 == 34
4/11/25 14:20 == 34.3	4/11/25 18:50 == 34.5	4/11/25 23:20 == 34	4/12/25 3:50 == 34.2
4/11/25 14:25 == 34.1	4/11/25 18:55 == 34.4	4/11/25 23:25 == 34.2	4/12/25 3:55 == 34.1
4/11/25 14:30 == 33.8	4/11/25 19:00 == 34.1	4/11/25 23:30 == 34.4	4/12/25 4:00 == 34.2
4/11/25 14:35 == 33.7	4/11/25 19:05 == 34	4/11/25 23:35 == 34.4	4/12/25 4:05 == 34.4
4/11/25 14:40 == 33.8	4/11/25 19:10 == 33.9	4/11/25 23:40 == 34.1	4/12/25 4:10 == 34.6
4/11/25 14:45 == 34	4/11/25 19:15 == 33.9	4/11/25 23:45 == 34	4/12/25 4:15 == 34.6
4/11/25 14:50 == 34.1	4/11/25 19:20 == 33.9	4/11/25 23:50 == 34.1	4/12/25 4:20 == 34.5
4/11/25 14:55 == 34.1	4/11/25 19:25 == 34	4/11/25 23:55 == 34.1	4/12/25 4:25 == 34.9
4/11/25 15:00 == 34	4/11/25 19:30 == 33.9	4/12/25 0:00 == 34	4/12/25 4:30 == 34.1
4/11/25 15:05 == 34.2	4/11/25 19:35 == 34	4/12/25 0:05 == 40.5	4/12/25 4:35 == 39.2
4/11/25 15:10 == 34.4	4/11/25 19:40 == 34.2	4/12/25 0:10 == 46.4	4/12/25 4:40 == 46.6
4/11/25 15:15 == 34.5	4/11/25 19:45 == 34.3	4/12/25 0:15 == 47.9	4/12/25 4:45 == 47.4
4/11/25 15:20 == 34.6	4/11/25 19:50 == 34.3	4/12/25 0:20 == 48	4/12/25 4:50 == 47.8
4/11/25 15:25 == 34.8	4/11/25 19:55 == 34.5	4/12/25 0:25 == 48	4/12/25 4:55 == 47.9
4/11/25 15:30 == 34.5	4/11/25 20:00 == 35.1	4/12/25 0:30 == 48.1	4/12/25 5:00 == 48
4/11/25 15:35 == 34.4	4/11/25 20:05 == 39.7	4/12/25 0:35 == 48	4/12/25 5:05 == 47.9
4/11/25 15:40 == 34.2	4/11/25 20:10 == 47.5	4/12/25 0:40 == 47.8	4/12/25 5:10 == 47.6
4/11/25 15:45 == 34.1	4/11/25 20:15 == 47.3	4/12/25 0:45 == 46.9	4/12/25 5:15 == 47.8
4/11/25 15:50 == 34	4/11/25 20:20 == 48	4/12/25 0:50 == 41.3	4/12/25 5:20 == 40.3
4/11/25 15:55 == 34.3	4/11/25 20:25 == 48.1	4/12/25 0:55 == 33.9	4/12/25 5:25 == 35
4/11/25 16:00 == 34.3	4/11/25 20:30 == 47.4	4/12/25 1:00 == 33.9	4/12/25 5:30 == 34.5
4/11/25 16:05 == 41.9	4/11/25 20:35 == 48.1	4/12/25 1:05 == 33.9	4/12/25 5:35 == 34.5
4/11/25 16:10 == 46.9	4/11/25 20:40 == 48	4/12/25 1:10 == 33.9	4/12/25 5:40 == 34.5
4/11/25 16:15 == 48	4/11/25 20:45 == 47.9	4/12/25 1:15 == 34	4/12/25 5:45 == 34.5
4/11/25 16:20 == 48	4/11/25 20:50 == 39.4	4/12/25 1:20 == 34	4/12/25 5:50 == 34.4
4/11/25 16:25 == 48	4/11/25 20:55 == 35.1	4/12/25 1:25 == 33.9	4/12/25 5:55 == 34.2

Pumpback Station Discharge (0364)

4/12/25 6:00 == 34	4/12/25 10:30 == 33.9	4/12/25 15:00 == 34.3	4/12/25 19:30 == 33.8
4/12/25 6:05 == 34	4/12/25 10:35 == 39.6	4/12/25 15:05 == 34.3	4/12/25 19:35 == 33.9
4/12/25 6:10 == 34	4/12/25 10:40 == 45.6	4/12/25 15:10 == 34.6	4/12/25 19:40 == 34.3
4/12/25 6:15 == 34.2	4/12/25 10:45 == 47.5	4/12/25 15:15 == 34.6	4/12/25 19:45 == 33.9
4/12/25 6:20 == 34.3	4/12/25 10:50 == 47.9	4/12/25 15:20 == 34.6	4/12/25 19:50 == 34.1
4/12/25 6:25 == 34.5	4/12/25 10:55 == 48.1	4/12/25 15:25 == 34.7	4/12/25 19:55 == 34.1
4/12/25 6:30 == 34.7	4/12/25 11:00 == 48	4/12/25 15:30 == 34.9	4/12/25 20:00 == 34.2
4/12/25 6:35 == 34.7	4/12/25 11:05 == 48	4/12/25 15:35 == 34.9	4/12/25 20:05 == 36.9
4/12/25 6:40 == 34.6	4/12/25 11:10 == 47.7	4/12/25 15:40 == 34.8	4/12/25 20:10 == 46.6
4/12/25 6:45 == 34.4	4/12/25 11:15 == 46.8	4/12/25 15:45 == 34.8	4/12/25 20:15 == 48
4/12/25 6:50 == 34.1	4/12/25 11:20 == 42.5	4/12/25 15:50 == 34.9	4/12/25 20:20 == 48.1
4/12/25 6:55 == 34.3	4/12/25 11:25 == 34.5	4/12/25 15:55 == 34.9	4/12/25 20:25 == 47.6
4/12/25 7:00 == 34	4/12/25 11:30 == 34.4	4/12/25 16:00 == 34.9	4/12/25 20:30 == 47.6
4/12/25 7:05 == 33.9	4/12/25 11:35 == 34.7	4/12/25 16:05 == 35.1	4/12/25 20:35 == 47.9
4/12/25 7:10 == 34.3	4/12/25 11:40 == 34.7	4/12/25 16:10 == 35.1	4/12/25 20:40 == 48
4/12/25 7:15 == 34	4/12/25 11:45 == 34.4	4/12/25 16:15 == 34.9	4/12/25 20:45 == 48
4/12/25 7:20 == 34	4/12/25 11:50 == 34.3	4/12/25 16:20 == 34.6	4/12/25 20:50 == 42.2
4/12/25 7:25 == 33.9	4/12/25 11:55 == 34.6	4/12/25 16:25 == 34.5	4/12/25 20:55 == 36.1
4/12/25 7:30 == 34	4/12/25 12:00 == 34	4/12/25 16:30 == 34.6	4/12/25 21:00 == 34.3
4/12/25 7:35 == 33.9	4/12/25 12:05 == 34.1	4/12/25 16:35 == 34.5	4/12/25 21:05 == 34.3
4/12/25 7:40 == 33.9	4/12/25 12:10 == 34	4/12/25 16:40 == 34.4	4/12/25 21:10 == 34.3
4/12/25 7:45 == 34	4/12/25 12:15 == 33.6	4/12/25 16:45 == 34.4	4/12/25 21:15 == 34.3
4/12/25 7:50 == 33.9	4/12/25 12:20 == 33.6	4/12/25 16:50 == 34.5	4/12/25 21:20 == 34.3
4/12/25 7:55 == 34	4/12/25 12:25 == 33.7	4/12/25 16:55 == 34.5	4/12/25 21:25 == 34.3
4/12/25 8:00 == 34.1	4/12/25 12:30 == 33.7	4/12/25 17:00 == 34.4	4/12/25 21:30 == 34.4
4/12/25 8:05 == 34	4/12/25 12:35 == 33.6	4/12/25 17:05 == 34.5	4/12/25 21:35 == 34.4
4/12/25 8:10 == 33.8	4/12/25 12:40 == 33.6	4/12/25 17:10 == 34.7	4/12/25 21:40 == 34.5
4/12/25 8:15 == 33.8	4/12/25 12:45 == 33.7	4/12/25 17:15 == 34.7	4/12/25 21:45 == 34.4
4/12/25 8:20 == 33.8	4/12/25 12:50 == 33.6	4/12/25 17:20 == 34.5	4/12/25 21:50 == 34.4
4/12/25 8:25 == 33.6	4/12/25 12:55 == 33.6	4/12/25 17:25 == 34.5	4/12/25 21:55 == 34.4
4/12/25 8:30 == 33.5	4/12/25 13:00 == 33.5	4/12/25 17:30 == 34.5	4/12/25 22:00 == 34.4
4/12/25 8:35 == 33.5	4/12/25 13:05 == 33.4	4/12/25 17:35 == 34.3	4/12/25 22:05 == 34.2
4/12/25 8:40 == 33.6	4/12/25 13:10 == 33.4	4/12/25 17:40 == 34.6	4/12/25 22:10 == 34.4
4/12/25 8:45 == 33.9	4/12/25 13:15 == 33.6	4/12/25 17:45 == 34.5	4/12/25 22:15 == 34.1
4/12/25 8:50 == 33.7	4/12/25 13:20 == 33.6	4/12/25 17:50 == 34.5	4/12/25 22:20 == 34.2
4/12/25 8:55 == 33.7	4/12/25 13:25 == 33.8	4/12/25 17:55 == 34.4	4/12/25 22:25 == 34.3
4/12/25 9:00 == 33.7	4/12/25 13:30 == 33.8	4/12/25 18:00 == 34.3	4/12/25 22:30 == 34.3
4/12/25 9:05 == 33.7	4/12/25 13:35 == 38.4	4/12/25 18:05 == 34.3	4/12/25 22:35 == 34.3
4/12/25 9:10 == 33.8	4/12/25 13:40 == 45.8	4/12/25 18:10 == 34.5	4/12/25 22:40 == 34.2
4/12/25 9:15 == 33.7	4/12/25 13:45 == 47.9	4/12/25 18:15 == 34.3	4/12/25 22:45 == 34
4/12/25 9:20 == 33.7	4/12/25 13:50 == 48	4/12/25 18:20 == 34.3	4/12/25 22:50 == 34.2
4/12/25 9:25 == 33.8	4/12/25 13:55 == 47.9	4/12/25 18:25 == 34.3	4/12/25 22:55 == 34.1
4/12/25 9:30 == 33.7	4/12/25 14:00 == 47.5	4/12/25 18:30 == 34.3	4/12/25 23:00 == 33.9
4/12/25 9:35 == 33.7	4/12/25 14:05 == 48	4/12/25 18:35 == 34.3	4/12/25 23:05 == 33.9
4/12/25 9:40 == 33.9	4/12/25 14:10 == 48.1	4/12/25 18:40 == 34.3	4/12/25 23:10 == 33.9
4/12/25 9:45 == 33.9	4/12/25 14:15 == 47.6	4/12/25 18:45 == 34.3	4/12/25 23:15 == 33.9
4/12/25 9:50 == 33.9	4/12/25 14:20 == 42.9	4/12/25 18:50 == 34.2	4/12/25 23:20 == 33.9
4/12/25 9:55 == 33.8	4/12/25 14:25 == 34.3	4/12/25 18:55 == 34.1	4/12/25 23:25 == 33.9
4/12/25 10:00 == 33.9	4/12/25 14:30 == 33.8	4/12/25 19:00 == 34.1	4/12/25 23:30 == 33.9
4/12/25 10:05 == 33.8	4/12/25 14:35 == 34.1	4/12/25 19:05 == 33.9	4/12/25 23:35 == 33.8
4/12/25 10:10 == 33.7	4/12/25 14:40 == 34.5	4/12/25 19:10 == 34	4/12/25 23:40 == 33.8
4/12/25 10:15 == 33.7	4/12/25 14:45 == 34	4/12/25 19:15 == 34	4/12/25 23:45 == 33.7
4/12/25 10:20 == 33.7	4/12/25 14:50 == 34.3	4/12/25 19:20 == 34.1	4/12/25 23:50 == 33.7
4/12/25 10:25 == 33.8	4/12/25 14:55 == 34.4	4/12/25 19:25 == 33.9	4/12/25 23:55 == 33.6

Pumpback Station Discharge (0364)

4/13/25 0:00 == 33.6	4/13/25 4:30 == 48.1	4/13/25 9:00 == 33.8	4/13/25 13:30 == 34.5
4/13/25 0:05 == 33.6	4/13/25 4:35 == 43	4/13/25 9:05 == 33.8	4/13/25 13:35 == 34.3
4/13/25 0:10 == 33.7	4/13/25 4:40 == 36.5	4/13/25 9:10 == 33.9	4/13/25 13:40 == 34.2
4/13/25 0:15 == 33.7	4/13/25 4:45 == 33.9	4/13/25 9:15 == 33.8	4/13/25 13:45 == 34.2
4/13/25 0:20 == 36.5	4/13/25 4:50 == 33.9	4/13/25 9:20 == 33.8	4/13/25 13:50 == 34.2
4/13/25 0:25 == 45.6	4/13/25 4:55 == 34	4/13/25 9:25 == 33.9	4/13/25 13:55 == 34.1
4/13/25 0:30 == 47.9	4/13/25 5:00 == 34	4/13/25 9:30 == 34	4/13/25 14:00 == 34
4/13/25 0:35 == 47.9	4/13/25 5:05 == 34	4/13/25 9:35 == 34	4/13/25 14:05 == 34.1
4/13/25 0:40 == 47.8	4/13/25 5:10 == 34.1	4/13/25 9:40 == 34	4/13/25 14:10 == 34.1
4/13/25 0:45 == 47.7	4/13/25 5:15 == 34	4/13/25 9:45 == 34	4/13/25 14:15 == 34
4/13/25 0:50 == 45	4/13/25 5:20 == 33.9	4/13/25 9:50 == 34.1	4/13/25 14:20 == 34
4/13/25 0:55 == 34	4/13/25 5:25 == 34	4/13/25 9:55 == 34	4/13/25 14:25 == 33.9
4/13/25 1:00 == 33.7	4/13/25 5:30 == 34	4/13/25 10:00 == 34	4/13/25 14:30 == 33.7
4/13/25 1:05 == 33.8	4/13/25 5:35 == 34	4/13/25 10:05 == 34.1	4/13/25 14:35 == 33.6
4/13/25 1:10 == 33.7	4/13/25 5:40 == 34.1	4/13/25 10:10 == 34.1	4/13/25 14:40 == 33.8
4/13/25 1:15 == 33.8	4/13/25 5:45 == 33.9	4/13/25 10:15 == 34	4/13/25 14:45 == 33.8
4/13/25 1:20 == 33.7	4/13/25 5:50 == 33.9	4/13/25 10:20 == 34	4/13/25 14:50 == 33.8
4/13/25 1:25 == 33.6	4/13/25 5:55 == 33.8	4/13/25 10:25 == 34.1	4/13/25 14:55 == 33.7
4/13/25 1:30 == 33.5	4/13/25 6:00 == 34	4/13/25 10:30 == 34	4/13/25 15:00 == 33.8
4/13/25 1:35 == 33.4	4/13/25 6:05 == 33.7	4/13/25 10:35 == 34	4/13/25 15:05 == 33.8
4/13/25 1:40 == 33.4	4/13/25 6:10 == 33.9	4/13/25 10:40 == 34.4	4/13/25 15:10 == 33.9
4/13/25 1:45 == 33.5	4/13/25 6:15 == 34	4/13/25 10:45 == 34.4	4/13/25 15:15 == 34
4/13/25 1:50 == 33.5	4/13/25 6:20 == 34	4/13/25 10:50 == 34.5	4/13/25 15:20 == 34.1
4/13/25 1:55 == 34	4/13/25 6:25 == 34.1	4/13/25 10:55 == 34.5	4/13/25 15:25 == 34.3
4/13/25 2:00 == 34.1	4/13/25 6:30 == 34.2	4/13/25 11:00 == 34.8	4/13/25 15:30 == 34.4
4/13/25 2:05 == 34	4/13/25 6:35 == 34.2	4/13/25 11:05 == 34.4	4/13/25 15:35 == 34.4
4/13/25 2:10 == 34	4/13/25 6:40 == 34.3	4/13/25 11:10 == 34.9	4/13/25 15:40 == 34.5
4/13/25 2:15 == 34.1	4/13/25 6:45 == 34.4	4/13/25 11:15 == 34.9	4/13/25 15:45 == 34.5
4/13/25 2:20 == 34.1	4/13/25 6:50 == 34.3	4/13/25 11:20 == 34.7	4/13/25 15:50 == 34.5
4/13/25 2:25 == 34.1	4/13/25 6:55 == 34.5	4/13/25 11:25 == 34.7	4/13/25 15:55 == 34.5
4/13/25 2:30 == 34.2	4/13/25 7:00 == 34.4	4/13/25 11:30 == 34.7	4/13/25 16:00 == 34.4
4/13/25 2:35 == 34.2	4/13/25 7:05 == 34.3	4/13/25 11:35 == 34.9	4/13/25 16:05 == 34.6
4/13/25 2:40 == 34.1	4/13/25 7:10 == 34.7	4/13/25 11:40 == 35.1	4/13/25 16:10 == 34.5
4/13/25 2:45 == 34.2	4/13/25 7:15 == 34.9	4/13/25 11:45 == 34.9	4/13/25 16:15 == 34.5
4/13/25 2:50 == 34.2	4/13/25 7:20 == 34.8	4/13/25 11:50 == 34.9	4/13/25 16:20 == 34.4
4/13/25 2:55 == 33.9	4/13/25 7:25 == 34.8	4/13/25 11:55 == 34.7	4/13/25 16:25 == 34.4
4/13/25 3:00 == 33.5	4/13/25 7:30 == 34.8	4/13/25 12:00 == 34.6	4/13/25 16:30 == 34.4
4/13/25 3:05 == 33.9	4/13/25 7:35 == 34.7	4/13/25 12:05 == 36.5	4/13/25 16:35 == 34.3
4/13/25 3:10 == 34	4/13/25 7:40 == 34.6	4/13/25 12:10 == 44.1	4/13/25 16:40 == 34.2
4/13/25 3:15 == 33.9	4/13/25 7:45 == 34.5	4/13/25 12:15 == 47.8	4/13/25 16:45 == 34.2
4/13/25 3:20 == 33.9	4/13/25 7:50 == 34.4	4/13/25 12:20 == 47.6	4/13/25 16:50 == 34.1
4/13/25 3:25 == 34.1	4/13/25 7:55 == 34.3	4/13/25 12:25 == 47.8	4/13/25 16:55 == 34.2
4/13/25 3:30 == 33.8	4/13/25 8:00 == 34.4	4/13/25 12:30 == 48.1	4/13/25 17:00 == 34.2
4/13/25 3:35 == 33.8	4/13/25 8:05 == 34.4	4/13/25 12:35 == 48.1	4/13/25 17:05 == 34
4/13/25 3:40 == 33.9	4/13/25 8:10 == 34.5	4/13/25 12:40 == 48	4/13/25 17:10 == 34.3
4/13/25 3:45 == 33.9	4/13/25 8:15 == 34.3	4/13/25 12:45 == 48	4/13/25 17:15 == 34.5
4/13/25 3:50 == 35.3	4/13/25 8:20 == 34.2	4/13/25 12:50 == 44.1	4/13/25 17:20 == 34.5
4/13/25 3:55 == 46.2	4/13/25 8:25 == 34.2	4/13/25 12:55 == 36.9	4/13/25 17:25 == 34.4
4/13/25 4:00 == 47.9	4/13/25 8:30 == 33.8	4/13/25 13:00 == 34.1	4/13/25 17:30 == 34.3
4/13/25 4:05 == 47.9	4/13/25 8:35 == 33.6	4/13/25 13:05 == 34.2	4/13/25 17:35 == 34.4
4/13/25 4:10 == 48	4/13/25 8:40 == 33.9	4/13/25 13:10 == 34.2	4/13/25 17:40 == 34.3
4/13/25 4:15 == 47.9	4/13/25 8:45 == 34	4/13/25 13:15 == 34.2	4/13/25 17:45 == 34.2
4/13/25 4:20 == 48	4/13/25 8:50 == 34	4/13/25 13:20 == 34.1	4/13/25 17:50 == 34.2
4/13/25 4:25 == 48.1	4/13/25 8:55 == 33.9	4/13/25 13:25 == 34.3	4/13/25 17:55 == 34.2

Pumpback Station Discharge (0364)

4/13/25 18:00 == 34	4/13/25 22:30 == 47.8	4/14/25 3:00 == 33.7	4/14/25 7:30 == 48
4/13/25 18:05 == 33.9	4/13/25 22:35 == 48	4/14/25 3:05 == 33.6	4/14/25 7:35 == 48.1
4/13/25 18:10 == 34	4/13/25 22:40 == 47.5	4/14/25 3:10 == 33.9	4/14/25 7:40 == 48.1
4/13/25 18:15 == 34	4/13/25 22:45 == 47.5	4/14/25 3:15 == 33.9	4/14/25 7:45 == 48.1
4/13/25 18:20 == 36	4/13/25 22:50 == 44.5	4/14/25 3:20 == 33.8	4/14/25 7:50 == 47.9
4/13/25 18:25 == 43.5	4/13/25 22:55 == 37.7	4/14/25 3:25 == 33.7	4/14/25 7:55 == 36.9
4/13/25 18:30 == 47.7	4/13/25 23:00 == 33.7	4/14/25 3:30 == 33.7	4/14/25 8:00 == 34.5
4/13/25 18:35 == 47.9	4/13/25 23:05 == 33.8	4/14/25 3:35 == 33.8	4/14/25 8:05 == 34.5
4/13/25 18:40 == 48	4/13/25 23:10 == 33.7	4/14/25 3:40 == 33.7	4/14/25 8:10 == 34.3
4/13/25 18:45 == 48	4/13/25 23:15 == 33.7	4/14/25 3:45 == 33.7	4/14/25 8:15 == 34.1
4/13/25 18:50 == 48	4/13/25 23:20 == 33.8	4/14/25 3:50 == 33.7	4/14/25 8:20 == 34.1
4/13/25 18:55 == 47.9	4/13/25 23:25 == 33.7	4/14/25 3:55 == 33.7	4/14/25 8:25 == 34
4/13/25 19:00 == 48	4/13/25 23:30 == 33.8	4/14/25 4:00 == 33.7	4/14/25 8:30 == 33.7
4/13/25 19:05 == 47.4	4/13/25 23:35 == 33.8	4/14/25 4:05 == 35.3	4/14/25 8:35 == 33.7
4/13/25 19:10 == 34.4	4/13/25 23:40 == 33.7	4/14/25 4:10 == 41.7	4/14/25 8:40 == 34
4/13/25 19:15 == 33.8	4/13/25 23:45 == 33.7	4/14/25 4:15 == 47.6	4/14/25 8:45 == 33.9
4/13/25 19:20 == 33.9	4/13/25 23:50 == 33.6	4/14/25 4:20 == 47.9	4/14/25 8:50 == 33.8
4/13/25 19:25 == 33.7	4/13/25 23:55 == 33.7	4/14/25 4:25 == 48	4/14/25 8:55 == 33.8
4/13/25 19:30 == 33.8	4/14/25 0:00 == 33.6	4/14/25 4:30 == 48	4/14/25 9:00 == 33.7
4/13/25 19:35 == 33.8	4/14/25 0:05 == 33.7	4/14/25 4:35 == 45.4	4/14/25 9:05 == 33.7
4/13/25 19:40 == 34	4/14/25 0:10 == 33.7	4/14/25 4:40 == 38.1	4/14/25 9:10 == 33.8
4/13/25 19:45 == 33.8	4/14/25 0:15 == 33.4	4/14/25 4:45 == 33.6	4/14/25 9:15 == 33.7
4/13/25 19:50 == 33.8	4/14/25 0:20 == 33.5	4/14/25 4:50 == 33.4	4/14/25 9:20 == 33.7
4/13/25 19:55 == 33.7	4/14/25 0:25 == 33.6	4/14/25 4:55 == 33.6	4/14/25 9:25 == 33.8
4/13/25 20:00 == 33.7	4/14/25 0:30 == 33.6	4/14/25 5:00 == 33.5	4/14/25 9:30 == 33.9
4/13/25 20:05 == 33.6	4/14/25 0:35 == 33.5	4/14/25 5:05 == 33.6	4/14/25 9:35 == 33.9
4/13/25 20:10 == 33.7	4/14/25 0:40 == 33.7	4/14/25 5:10 == 33.6	4/14/25 9:40 == 33.8
4/13/25 20:15 == 33.9	4/14/25 0:45 == 33.8	4/14/25 5:15 == 33.4	4/14/25 9:45 == 34
4/13/25 20:20 == 33.9	4/14/25 0:50 == 33.8	4/14/25 5:20 == 33.5	4/14/25 9:50 == 34
4/13/25 20:25 == 34.2	4/14/25 0:55 == 33.7	4/14/25 5:25 == 33.6	4/14/25 9:55 == 33.9
4/13/25 20:30 == 34.3	4/14/25 1:00 == 33.6	4/14/25 5:30 == 33.7	4/14/25 10:00 == 33.8
4/13/25 20:35 == 34.1	4/14/25 1:05 == 34.6	4/14/25 5:35 == 33.6	4/14/25 10:05 == 34
4/13/25 20:40 == 34.2	4/14/25 1:10 == 42.8	4/14/25 5:40 == 33.8	4/14/25 10:10 == 34
4/13/25 20:45 == 34.3	4/14/25 1:15 == 47.8	4/14/25 5:45 == 33.6	4/14/25 10:15 == 34.1
4/13/25 20:50 == 34.3	4/14/25 1:20 == 48.1	4/14/25 5:50 == 33.6	4/14/25 10:20 == 33.9
4/13/25 20:55 == 34.2	4/14/25 1:25 == 48	4/14/25 5:55 == 33.6	4/14/25 10:25 == 34.3
4/13/25 21:00 == 33.9	4/14/25 1:30 == 47.9	4/14/25 6:00 == 33.6	4/14/25 10:30 == 34.1
4/13/25 21:05 == 33.8	4/14/25 1:35 == 44.7	4/14/25 6:05 == 33.7	4/14/25 10:35 == 34.2
4/13/25 21:10 == 34	4/14/25 1:40 == 37.7	4/14/25 6:10 == 33.8	4/14/25 10:40 == 34.7
4/13/25 21:15 == 33.8	4/14/25 1:45 == 33.4	4/14/25 6:15 == 33.7	4/14/25 10:45 == 34.6
4/13/25 21:20 == 34.1	4/14/25 1:50 == 33.5	4/14/25 6:20 == 33.7	4/14/25 10:50 == 34.8
4/13/25 21:25 == 34	4/14/25 1:55 == 33.9	4/14/25 6:25 == 33.8	4/14/25 10:55 == 34.8
4/13/25 21:30 == 33.8	4/14/25 2:00 == 34.2	4/14/25 6:30 == 33.9	4/14/25 11:00 == 35
4/13/25 21:35 == 33.9	4/14/25 2:05 == 34.1	4/14/25 6:35 == 33.9	4/14/25 11:05 == 35
4/13/25 21:40 == 34	4/14/25 2:10 == 34.2	4/14/25 6:40 == 33.9	4/14/25 11:10 == 35.2
4/13/25 21:45 == 33.9	4/14/25 2:15 == 34.1	4/14/25 6:45 == 33.9	4/14/25 11:15 == 35.3
4/13/25 21:50 == 34.1	4/14/25 2:20 == 34	4/14/25 6:50 == 34	4/14/25 11:20 == 35.3
4/13/25 21:55 == 34.2	4/14/25 2:25 == 34.2	4/14/25 6:55 == 34.2	4/14/25 11:25 == 35.1
4/13/25 22:00 == 34	4/14/25 2:30 == 34.2	4/14/25 7:00 == 34.2	4/14/25 11:30 == 35.1
4/13/25 22:05 == 33.9	4/14/25 2:35 == 34.1	4/14/25 7:05 == 35.8	4/14/25 11:35 == 35
4/13/25 22:10 == 33.8	4/14/25 2:40 == 34.1	4/14/25 7:10 == 41.7	4/14/25 11:40 == 35.2
4/13/25 22:15 == 33.9	4/14/25 2:45 == 34.1	4/14/25 7:15 == 47.3	4/14/25 11:45 == 35.2
4/13/25 22:20 == 34.8	4/14/25 2:50 == 34.3	4/14/25 7:20 == 48	4/14/25 11:50 == 35.1
4/13/25 22:25 == 43.6	4/14/25 2:55 == 34	4/14/25 7:25 == 47.9	4/14/25 11:55 == 35.1

Pumpback Station Discharge (0364)

4/14/25 12:00 == 34.9	4/14/25 16:30 == 34.4	4/14/25 21:00 == 47.2	4/15/25 1:30 == 33.8
4/14/25 12:05 == 34.9	4/14/25 16:35 == 34.4	4/14/25 21:05 == 47.9	4/15/25 1:35 == 34
4/14/25 12:10 == 34.8	4/14/25 16:40 == 34.5	4/14/25 21:10 == 47.5	4/15/25 1:40 == 34.2
4/14/25 12:15 == 34.4	4/14/25 16:45 == 34.3	4/14/25 21:15 == 47.9	4/15/25 1:45 == 34
4/14/25 12:20 == 35.7	4/14/25 16:50 == 34.2	4/14/25 21:20 == 48.1	4/15/25 1:50 == 34.2
4/14/25 12:25 == 41.2	4/14/25 16:55 == 34.2	4/14/25 21:25 == 48	4/15/25 1:55 == 34.4
4/14/25 12:30 == 47.8	4/14/25 17:00 == 34	4/14/25 21:30 == 47.9	4/15/25 2:00 == 34.2
4/14/25 12:35 == 48	4/14/25 17:05 == 34.1	4/14/25 21:35 == 47.6	4/15/25 2:05 == 34.3
4/14/25 12:40 == 48	4/14/25 17:10 == 34.3	4/14/25 21:40 == 47.8	4/15/25 2:10 == 34.5
4/14/25 12:45 == 47.9	4/14/25 17:15 == 34.6	4/14/25 21:45 == 47.9	4/15/25 2:15 == 34.3
4/14/25 12:50 == 48.1	4/14/25 17:20 == 34.5	4/14/25 21:50 == 47.2	4/15/25 2:20 == 34.4
4/14/25 12:55 == 48	4/14/25 17:25 == 34.5	4/14/25 21:55 == 39.7	4/15/25 2:25 == 34.4
4/14/25 13:00 == 47.8	4/14/25 17:30 == 34.5	4/14/25 22:00 == 34.2	4/15/25 2:30 == 34.4
4/14/25 13:05 == 48	4/14/25 17:35 == 34.5	4/14/25 22:05 == 33.9	4/15/25 2:35 == 34.5
4/14/25 13:10 == 37.4	4/14/25 17:40 == 34.7	4/14/25 22:10 == 33.9	4/15/25 2:40 == 34.6
4/14/25 13:15 == 34.4	4/14/25 17:45 == 34.6	4/14/25 22:15 == 34	4/15/25 2:45 == 34.4
4/14/25 13:20 == 34.2	4/14/25 17:50 == 34.7	4/14/25 22:20 == 33.9	4/15/25 2:50 == 34.4
4/14/25 13:25 == 34.3	4/14/25 17:55 == 34.7	4/14/25 22:25 == 33.9	4/15/25 2:55 == 41.3
4/14/25 13:30 == 34.1	4/14/25 18:00 == 34.6	4/14/25 22:30 == 34.1	4/15/25 3:00 == 47
4/14/25 13:35 == 34.1	4/14/25 18:05 == 34.6	4/14/25 22:35 == 34.1	4/15/25 3:05 == 48
4/14/25 13:40 == 34.2	4/14/25 18:10 == 34.7	4/14/25 22:40 == 34.2	4/15/25 3:10 == 48.1
4/14/25 13:45 == 34.2	4/14/25 18:15 == 34.1	4/14/25 22:45 == 34	4/15/25 3:15 == 48.1
4/14/25 13:50 == 34.3	4/14/25 18:20 == 33.9	4/14/25 22:50 == 33.9	4/15/25 3:20 == 48.1
4/14/25 13:55 == 34.2	4/14/25 18:25 == 34.2	4/14/25 22:55 == 33.9	4/15/25 3:25 == 48
4/14/25 14:00 == 34	4/14/25 18:30 == 33.9	4/14/25 23:00 == 34	4/15/25 3:30 == 48
4/14/25 14:05 == 34	4/14/25 18:35 == 34.1	4/14/25 23:05 == 33.9	4/15/25 3:35 == 46.8
4/14/25 14:10 == 34	4/14/25 18:40 == 42.2	4/14/25 23:10 == 33.9	4/15/25 3:40 == 41.1
4/14/25 14:15 == 34	4/14/25 18:45 == 47.3	4/14/25 23:15 == 33.9	4/15/25 3:45 == 33.8
4/14/25 14:20 == 34	4/14/25 18:50 == 48	4/14/25 23:20 == 33.9	4/15/25 3:50 == 33.6
4/14/25 14:25 == 33.9	4/14/25 18:55 == 48.1	4/14/25 23:25 == 33.8	4/15/25 3:55 == 33.7
4/14/25 14:30 == 33.9	4/14/25 19:00 == 47.9	4/14/25 23:30 == 34	4/15/25 4:00 == 33.7
4/14/25 14:35 == 34	4/14/25 19:05 == 47.9	4/14/25 23:35 == 34	4/15/25 4:05 == 33.8
4/14/25 14:40 == 34.2	4/14/25 19:10 == 47.9	4/14/25 23:40 == 33.8	4/15/25 4:10 == 33.7
4/14/25 14:45 == 34.4	4/14/25 19:15 == 48	4/14/25 23:45 == 33.6	4/15/25 4:15 == 33.7
4/14/25 14:50 == 34.3	4/14/25 19:20 == 46.8	4/14/25 23:50 == 33.8	4/15/25 4:20 == 33.6
4/14/25 14:55 == 34.3	4/14/25 19:25 == 39.4	4/14/25 23:55 == 33.8	4/15/25 4:25 == 34.1
4/14/25 15:00 == 34.3	4/14/25 19:30 == 33.9	4/15/25 0:00 == 33.7	4/15/25 4:30 == 33.7
4/14/25 15:05 == 34.3	4/14/25 19:35 == 33.9	4/15/25 0:05 == 33.6	4/15/25 4:35 == 33.7
4/14/25 15:10 == 34.3	4/14/25 19:40 == 34.1	4/15/25 0:10 == 40.9	4/15/25 4:40 == 33.7
4/14/25 15:15 == 34.2	4/14/25 19:45 == 34.1	4/15/25 0:15 == 46.3	4/15/25 4:45 == 33.6
4/14/25 15:20 == 35.1	4/14/25 19:50 == 34	4/15/25 0:20 == 47.8	4/15/25 4:50 == 33.6
4/14/25 15:25 == 41.5	4/14/25 19:55 == 34	4/15/25 0:25 == 48	4/15/25 4:55 == 39.6
4/14/25 15:30 == 47.6	4/14/25 20:00 == 33.9	4/15/25 0:30 == 47.9	4/15/25 5:00 == 46.5
4/14/25 15:35 == 48	4/14/25 20:05 == 33.9	4/15/25 0:35 == 47.9	4/15/25 5:05 == 47.8
4/14/25 15:40 == 48	4/14/25 20:10 == 34.1	4/15/25 0:40 == 48	4/15/25 5:10 == 47.8
4/14/25 15:45 == 47.8	4/14/25 20:15 == 33.9	4/15/25 0:45 == 48	4/15/25 5:15 == 48
4/14/25 15:50 == 47.9	4/14/25 20:20 == 33.9	4/15/25 0:50 == 48	4/15/25 5:20 == 47.9
4/14/25 15:55 == 47.9	4/14/25 20:25 == 34.1	4/15/25 0:55 == 48	4/15/25 5:25 == 48
4/14/25 16:00 == 47.9	4/14/25 20:30 == 34.3	4/15/25 1:00 == 48	4/15/25 5:30 == 48.1
4/14/25 16:05 == 48.2	4/14/25 20:35 == 34.4	4/15/25 1:05 == 46.7	4/15/25 5:35 == 48
4/14/25 16:10 == 38.4	4/14/25 20:40 == 34.4	4/15/25 1:10 == 40.9	4/15/25 5:40 == 40.1
4/14/25 16:15 == 35	4/14/25 20:45 == 34.2	4/15/25 1:15 == 33.8	4/15/25 5:45 == 33.9
4/14/25 16:20 == 34.4	4/14/25 20:50 == 34.1	4/15/25 1:20 == 33.8	4/15/25 5:50 == 33.8
4/14/25 16:25 == 34.4	4/14/25 20:55 == 40.6	4/15/25 1:25 == 33.8	4/15/25 5:55 == 33.9

Pumpback Station Discharge (0364)

4/15/25 6:00 == 33.8	4/15/25 10:30 == 34.5	4/15/25 15:00 == 48	4/15/25 19:30 == 33.3
4/15/25 6:05 == 33.8	4/15/25 10:35 == 33.6	4/15/25 15:05 == 48.1	4/15/25 19:35 == 33.3
4/15/25 6:10 == 33.8	4/15/25 10:40 == 34	4/15/25 15:10 == 41.3	4/15/25 19:40 == 33.6
4/15/25 6:15 == 33.9	4/15/25 10:45 == 34.2	4/15/25 15:15 == 34.9	4/15/25 19:45 == 33.4
4/15/25 6:20 == 33.9	4/15/25 10:50 == 34.2	4/15/25 15:20 == 34	4/15/25 19:50 == 33.5
4/15/25 6:25 == 34	4/15/25 10:55 == 34.2	4/15/25 15:25 == 33.9	4/15/25 19:55 == 33.5
4/15/25 6:30 == 34.1	4/15/25 11:00 == 34.2	4/15/25 15:30 == 33.9	4/15/25 20:00 == 33.5
4/15/25 6:35 == 34	4/15/25 11:05 == 34.3	4/15/25 15:35 == 34	4/15/25 20:05 == 33.5
4/15/25 6:40 == 33.7	4/15/25 11:10 == 34.5	4/15/25 15:40 == 33.8	4/15/25 20:10 == 33.6
4/15/25 6:45 == 33.8	4/15/25 11:15 == 34.6	4/15/25 15:45 == 33.9	4/15/25 20:15 == 33.7
4/15/25 6:50 == 33.9	4/15/25 11:20 == 34.5	4/15/25 15:50 == 34	4/15/25 20:20 == 33.7
4/15/25 6:55 == 38.6	4/15/25 11:25 == 34.5	4/15/25 15:55 == 33.9	4/15/25 20:25 == 37.5
4/15/25 7:00 == 48.1	4/15/25 11:30 == 34.6	4/15/25 16:00 == 33.9	4/15/25 20:30 == 46.2
4/15/25 7:05 == 47.8	4/15/25 11:35 == 34.7	4/15/25 16:05 == 33.9	4/15/25 20:35 == 48.1
4/15/25 7:10 == 47.7	4/15/25 11:40 == 38.2	4/15/25 16:10 == 39	4/15/25 20:40 == 47.9
4/15/25 7:15 == 47.8	4/15/25 11:45 == 47.9	4/15/25 16:15 == 46.1	4/15/25 20:45 == 48
4/15/25 7:20 == 47.9	4/15/25 11:50 == 47.9	4/15/25 16:20 == 48	4/15/25 20:50 == 48
4/15/25 7:25 == 48	4/15/25 11:55 == 48	4/15/25 16:25 == 48	4/15/25 20:55 == 48
4/15/25 7:30 == 48	4/15/25 12:00 == 47.8	4/15/25 16:30 == 48.2	4/15/25 21:00 == 48
4/15/25 7:35 == 48	4/15/25 12:05 == 48.1	4/15/25 16:35 == 47.9	4/15/25 21:05 == 48
4/15/25 7:40 == 40	4/15/25 12:10 == 47.4	4/15/25 16:40 == 48	4/15/25 21:10 == 47.7
4/15/25 7:45 == 34.9	4/15/25 12:15 == 47.7	4/15/25 16:45 == 48	4/15/25 21:15 == 47.8
4/15/25 7:50 == 33.9	4/15/25 12:20 == 47.5	4/15/25 16:50 == 47.5	4/15/25 21:20 == 48
4/15/25 7:55 == 34.2	4/15/25 12:25 == 47.8	4/15/25 16:55 == 43.4	4/15/25 21:25 == 42.4
4/15/25 8:00 == 34.2	4/15/25 12:30 == 48	4/15/25 17:00 == 33.7	4/15/25 21:30 == 34.7
4/15/25 8:05 == 34.3	4/15/25 12:35 == 48	4/15/25 17:05 == 33.8	4/15/25 21:35 == 33.7
4/15/25 8:10 == 34.1	4/15/25 12:40 == 48	4/15/25 17:10 == 34.1	4/15/25 21:40 == 33.6
4/15/25 8:15 == 34	4/15/25 12:45 == 48	4/15/25 17:15 == 34.1	4/15/25 21:45 == 33.6
4/15/25 8:20 == 34	4/15/25 12:50 == 48.1	4/15/25 17:20 == 34.2	4/15/25 21:50 == 33.6
4/15/25 8:25 == 34	4/15/25 12:55 == 40.6	4/15/25 17:25 == 34.2	4/15/25 21:55 == 33.6
4/15/25 8:30 == 33.9	4/15/25 13:00 == 35	4/15/25 17:30 == 34.2	4/15/25 22:00 == 33.6
4/15/25 8:35 == 33.7	4/15/25 13:05 == 33.8	4/15/25 17:35 == 34.2	4/15/25 22:05 == 33.7
4/15/25 8:40 == 33.8	4/15/25 13:10 == 33.9	4/15/25 17:40 == 34.1	4/15/25 22:10 == 33.7
4/15/25 8:45 == 33.9	4/15/25 13:15 == 33.9	4/15/25 17:45 == 34.2	4/15/25 22:15 == 33.6
4/15/25 8:50 == 33.8	4/15/25 13:20 == 33.8	4/15/25 17:50 == 34.2	4/15/25 22:20 == 33.9
4/15/25 8:55 == 33.8	4/15/25 13:25 == 34.1	4/15/25 17:55 == 34.1	4/15/25 22:25 == 35.5
4/15/25 9:00 == 33.7	4/15/25 13:30 == 34.3	4/15/25 18:00 == 34.1	4/15/25 22:30 == 47.4
4/15/25 9:05 == 33.7	4/15/25 13:35 == 34.2	4/15/25 18:05 == 34	4/15/25 22:35 == 47.9
4/15/25 9:10 == 33.7	4/15/25 13:40 == 34.2	4/15/25 18:10 == 39.2	4/15/25 22:40 == 47.3
4/15/25 9:15 == 33.7	4/15/25 13:45 == 34.3	4/15/25 18:15 == 45.5	4/15/25 22:45 == 47.8
4/15/25 9:20 == 33.6	4/15/25 13:50 == 34.3	4/15/25 18:20 == 47.7	4/15/25 22:50 == 47.9
4/15/25 9:25 == 33.8	4/15/25 13:55 == 34.2	4/15/25 18:25 == 48	4/15/25 22:55 == 47.8
4/15/25 9:30 == 34	4/15/25 14:00 == 34.1	4/15/25 18:30 == 48	4/15/25 23:00 == 48
4/15/25 9:35 == 33.8	4/15/25 14:05 == 34	4/15/25 18:35 == 47.9	4/15/25 23:05 == 47.9
4/15/25 9:40 == 38.1	4/15/25 14:10 == 37.5	4/15/25 18:40 == 47.9	4/15/25 23:10 == 47.8
4/15/25 9:45 == 47.5	4/15/25 14:15 == 47.5	4/15/25 18:45 == 48	4/15/25 23:15 == 47.9
4/15/25 9:50 == 47.9	4/15/25 14:20 == 47.9	4/15/25 18:50 == 48.1	4/15/25 23:20 == 47.8
4/15/25 9:55 == 48	4/15/25 14:25 == 47.9	4/15/25 18:55 == 48.1	4/15/25 23:25 == 41.7
4/15/25 10:00 == 48	4/15/25 14:30 == 47.4	4/15/25 19:00 == 47.9	4/15/25 23:30 == 35.4
4/15/25 10:05 == 48.1	4/15/25 14:35 == 48	4/15/25 19:05 == 47.8	4/15/25 23:35 == 33.5
4/15/25 10:10 == 48.1	4/15/25 14:40 == 47.7	4/15/25 19:10 == 47.9	4/15/25 23:40 == 33.4
4/15/25 10:15 == 48	4/15/25 14:45 == 47.6	4/15/25 19:15 == 48.1	4/15/25 23:45 == 33.4
4/15/25 10:20 == 48	4/15/25 14:50 == 48.1	4/15/25 19:20 == 47.6	4/15/25 23:50 == 33.4
4/15/25 10:25 == 39.9	4/15/25 14:55 == 47.8	4/15/25 19:25 == 43.2	4/15/25 23:55 == 33.4

Pumpback Station Discharge (0364)

4/16/25 0:00 == 33.3	4/16/25 4:30 == 33.4	4/16/25 9:00 == 33.9	4/16/25 13:30 == 35.1
4/16/25 0:05 == 33.3	4/16/25 4:35 == 33.4	4/16/25 9:05 == 33.9	4/16/25 13:35 == 35.1
4/16/25 0:10 == 33.3	4/16/25 4:40 == 37.2	4/16/25 9:10 == 34.8	4/16/25 13:40 == 35.1
4/16/25 0:15 == 33.3	4/16/25 4:45 == 44.1	4/16/25 9:15 == 45.7	4/16/25 13:45 == 35.2
4/16/25 0:20 == 33.4	4/16/25 4:50 == 47.6	4/16/25 9:20 == 48	4/16/25 13:50 == 35.2
4/16/25 0:25 == 36.4	4/16/25 4:55 == 47.9	4/16/25 9:25 == 47.9	4/16/25 13:55 == 35.6
4/16/25 0:30 == 45.5	4/16/25 5:00 == 47.9	4/16/25 9:30 == 47.9	4/16/25 14:00 == 46.1
4/16/25 0:35 == 47.9	4/16/25 5:05 == 48	4/16/25 9:35 == 47.9	4/16/25 14:05 == 48.2
4/16/25 0:40 == 48	4/16/25 5:10 == 48.1	4/16/25 9:40 == 48	4/16/25 14:10 == 48
4/16/25 0:45 == 48.2	4/16/25 5:15 == 48	4/16/25 9:45 == 48	4/16/25 14:15 == 48.2
4/16/25 0:50 == 48	4/16/25 5:20 == 48	4/16/25 9:50 == 47.9	4/16/25 14:20 == 48
4/16/25 0:55 == 48.2	4/16/25 5:25 == 47.8	4/16/25 9:55 == 47.9	4/16/25 14:25 == 48
4/16/25 1:00 == 48	4/16/25 5:30 == 47.6	4/16/25 10:00 == 48.1	4/16/25 14:30 == 47.8
4/16/25 1:05 == 47.9	4/16/25 5:35 == 47.9	4/16/25 10:05 == 48	4/16/25 14:35 == 47.8
4/16/25 1:10 == 48	4/16/25 5:40 == 47.9	4/16/25 10:10 == 43.2	4/16/25 14:40 == 47.2
4/16/25 1:15 == 47.8	4/16/25 5:45 == 47.4	4/16/25 10:15 == 36.3	4/16/25 14:45 == 47.6
4/16/25 1:20 == 48	4/16/25 5:50 == 47.7	4/16/25 10:20 == 34	4/16/25 14:50 == 47.8
4/16/25 1:25 == 43.2	4/16/25 5:55 == 45.1	4/16/25 10:25 == 34.2	4/16/25 14:55 == 47.7
4/16/25 1:30 == 34.8	4/16/25 6:00 == 33.4	4/16/25 10:30 == 34.5	4/16/25 15:00 == 47.8
4/16/25 1:35 == 33.7	4/16/25 6:05 == 33.4	4/16/25 10:35 == 34.4	4/16/25 15:05 == 47.9
4/16/25 1:40 == 34.1	4/16/25 6:10 == 33.4	4/16/25 10:40 == 34.6	4/16/25 15:10 == 43.9
4/16/25 1:45 == 34.1	4/16/25 6:15 == 33.5	4/16/25 10:45 == 34.9	4/16/25 15:15 == 37.7
4/16/25 1:50 == 34	4/16/25 6:20 == 33.5	4/16/25 10:50 == 34.8	4/16/25 15:20 == 35
4/16/25 1:55 == 34.2	4/16/25 6:25 == 33.7	4/16/25 10:55 == 34.9	4/16/25 15:25 == 35.2
4/16/25 2:00 == 34.2	4/16/25 6:30 == 33.7	4/16/25 11:00 == 35.1	4/16/25 15:30 == 35.2
4/16/25 2:05 == 34.2	4/16/25 6:35 == 33.7	4/16/25 11:05 == 35	4/16/25 15:35 == 35.2
4/16/25 2:10 == 34.2	4/16/25 6:40 == 33.9	4/16/25 11:10 == 34.9	4/16/25 15:40 == 35.3
4/16/25 2:15 == 34.1	4/16/25 6:45 == 33.7	4/16/25 11:15 == 35	4/16/25 15:45 == 35.3
4/16/25 2:20 == 34	4/16/25 6:50 == 33.8	4/16/25 11:20 == 34.9	4/16/25 15:50 == 35.3
4/16/25 2:25 == 38	4/16/25 6:55 == 37.1	4/16/25 11:25 == 35.2	4/16/25 15:55 == 35.3
4/16/25 2:30 == 44.7	4/16/25 7:00 == 45.2	4/16/25 11:30 == 47.7	4/16/25 16:00 == 35.2
4/16/25 2:35 == 47.8	4/16/25 7:05 == 47.9	4/16/25 11:35 == 47.8	4/16/25 16:05 == 35.1
4/16/25 2:40 == 47.8	4/16/25 7:10 == 47.6	4/16/25 11:40 == 47.8	4/16/25 16:10 == 36.7
4/16/25 2:45 == 48	4/16/25 7:15 == 47.8	4/16/25 11:45 == 47.7	4/16/25 16:15 == 45.1
4/16/25 2:50 == 48.1	4/16/25 7:20 == 47.8	4/16/25 11:50 == 47.5	4/16/25 16:20 == 48
4/16/25 2:55 == 47.9	4/16/25 7:25 == 47.8	4/16/25 11:55 == 47.9	4/16/25 16:25 == 48
4/16/25 3:00 == 47.6	4/16/25 7:30 == 47.9	4/16/25 12:00 == 48	4/16/25 16:30 == 47.8
4/16/25 3:05 == 48	4/16/25 7:35 == 48	4/16/25 12:05 == 47.7	4/16/25 16:35 == 47.9
4/16/25 3:10 == 48.2	4/16/25 7:40 == 48	4/16/25 12:10 == 47.7	4/16/25 16:40 == 48
4/16/25 3:15 == 48	4/16/25 7:45 == 47.9	4/16/25 12:15 == 47.9	4/16/25 16:45 == 48.1
4/16/25 3:20 == 47.9	4/16/25 7:50 == 47.9	4/16/25 12:20 == 48.1	4/16/25 16:50 == 47.9
4/16/25 3:25 == 47.8	4/16/25 7:55 == 47.8	4/16/25 12:25 == 48	4/16/25 16:55 == 48
4/16/25 3:30 == 47.5	4/16/25 8:00 == 47.5	4/16/25 12:30 == 48	4/16/25 17:00 == 48
4/16/25 3:35 == 47.8	4/16/25 8:05 == 47.9	4/16/25 12:35 == 48.1	4/16/25 17:05 == 47.9
4/16/25 3:40 == 44.2	4/16/25 8:10 == 44.5	4/16/25 12:40 == 43.9	4/16/25 17:10 == 45.2
4/16/25 3:45 == 33.2	4/16/25 8:15 == 34.9	4/16/25 12:45 == 37.4	4/16/25 17:15 == 37.6
4/16/25 3:50 == 33.4	4/16/25 8:20 == 34.3	4/16/25 12:50 == 34.7	4/16/25 17:20 == 35.3
4/16/25 3:55 == 33.3	4/16/25 8:25 == 34.3	4/16/25 12:55 == 34.7	4/16/25 17:25 == 35
4/16/25 4:00 == 33.3	4/16/25 8:30 == 34.2	4/16/25 13:00 == 34.7	4/16/25 17:30 == 35
4/16/25 4:05 == 33.4	4/16/25 8:35 == 34.1	4/16/25 13:05 == 34.6	4/16/25 17:35 == 35.1
4/16/25 4:10 == 33.4	4/16/25 8:40 == 34.1	4/16/25 13:10 == 34.6	4/16/25 17:40 == 35.1
4/16/25 4:15 == 33.5	4/16/25 8:45 == 34	4/16/25 13:15 == 34.5	4/16/25 17:45 == 35.1
4/16/25 4:20 == 33.4	4/16/25 8:50 == 34.1	4/16/25 13:20 == 34.4	4/16/25 17:50 == 35.1
4/16/25 4:25 == 33.4	4/16/25 8:55 == 33.7	4/16/25 13:25 == 34.7	4/16/25 17:55 == 35.1

Pumpback Station Discharge (0364)

4/16/25 18:00 == 35.2	4/16/25 22:30 == 37.2	4/17/25 3:00 == 47.7	4/17/25 7:30 == 48.1
4/16/25 18:05 == 35.2	4/16/25 22:35 == 34.6	4/17/25 3:05 == 47.9	4/17/25 7:35 == 47.9
4/16/25 18:10 == 35.1	4/16/25 22:40 == 34.5	4/17/25 3:10 == 48.1	4/17/25 7:40 == 47.9
4/16/25 18:15 == 34.8	4/16/25 22:45 == 34.4	4/17/25 3:15 == 47.8	4/17/25 7:45 == 48
4/16/25 18:20 == 34.7	4/16/25 22:50 == 34.4	4/17/25 3:20 == 48.1	4/17/25 7:50 == 48
4/16/25 18:25 == 37	4/16/25 22:55 == 34.5	4/17/25 3:25 == 48.1	4/17/25 7:55 == 47.6
4/16/25 18:30 == 43.9	4/16/25 23:00 == 34.4	4/17/25 3:30 == 48	4/17/25 8:00 == 37.3
4/16/25 18:35 == 47.5	4/16/25 23:05 == 34.4	4/17/25 3:35 == 48	4/17/25 8:05 == 35
4/16/25 18:40 == 47.8	4/16/25 23:10 == 34.4	4/17/25 3:40 == 45.8	4/17/25 8:10 == 34.8
4/16/25 18:45 == 48	4/16/25 23:15 == 34.3	4/17/25 3:45 == 37.6	4/17/25 8:15 == 34.8
4/16/25 18:50 == 48	4/16/25 23:20 == 34.3	4/17/25 3:50 == 34.2	4/17/25 8:20 == 34.5
4/16/25 18:55 == 47.8	4/16/25 23:25 == 36.5	4/17/25 3:55 == 34.1	4/17/25 8:25 == 34.7
4/16/25 19:00 == 47.9	4/16/25 23:30 == 42.7	4/17/25 4:00 == 34.2	4/17/25 8:30 == 34.3
4/16/25 19:05 == 48.1	4/16/25 23:35 == 47.7	4/17/25 4:05 == 34.3	4/17/25 8:35 == 34.2
4/16/25 19:10 == 48	4/16/25 23:40 == 47.9	4/17/25 4:10 == 34.4	4/17/25 8:40 == 34.6
4/16/25 19:15 == 47.9	4/16/25 23:45 == 48.1	4/17/25 4:15 == 34.4	4/17/25 8:45 == 43.6
4/16/25 19:20 == 48	4/16/25 23:50 == 48	4/17/25 4:20 == 34.4	4/17/25 8:50 == 47.7
4/16/25 19:25 == 48	4/16/25 23:55 == 48	4/17/25 4:25 == 34.6	4/17/25 8:55 == 48.1
4/16/25 19:30 == 48.1	4/17/25 0:00 == 48	4/17/25 4:30 == 34.6	4/17/25 9:00 == 48
4/16/25 19:35 == 47.9	4/17/25 0:05 == 48	4/17/25 4:35 == 34.4	4/17/25 9:05 == 48
4/16/25 19:40 == 47.6	4/17/25 0:10 == 48.1	4/17/25 4:40 == 36.1	4/17/25 9:10 == 48.1
4/16/25 19:45 == 47.9	4/17/25 0:15 == 48.1	4/17/25 4:45 == 41.9	4/17/25 9:15 == 47.9
4/16/25 19:50 == 48.1	4/17/25 0:20 == 48.1	4/17/25 4:50 == 47.6	4/17/25 9:20 == 47.8
4/16/25 19:55 == 47.9	4/17/25 0:25 == 47.6	4/17/25 4:55 == 48	4/17/25 9:25 == 48
4/16/25 20:00 == 47.8	4/17/25 0:30 == 48	4/17/25 5:00 == 48.1	4/17/25 9:30 == 48
4/16/25 20:05 == 47.9	4/17/25 0:35 == 47.9	4/17/25 5:05 == 47.8	4/17/25 9:35 == 48.1
4/16/25 20:10 == 44.7	4/17/25 0:40 == 48.1	4/17/25 5:10 == 48.1	4/17/25 9:40 == 45.6
4/16/25 20:15 == 38	4/17/25 0:45 == 48	4/17/25 5:15 == 47.9	4/17/25 9:45 == 39.1
4/16/25 20:20 == 34.6	4/17/25 0:50 == 48.1	4/17/25 5:20 == 48.3	4/17/25 9:50 == 34.5
4/16/25 20:25 == 34.8	4/17/25 0:55 == 48.1	4/17/25 5:25 == 48.1	4/17/25 9:55 == 34.6
4/16/25 20:30 == 35	4/17/25 1:00 == 48.1	4/17/25 5:30 == 48	4/17/25 10:00 == 34.6
4/16/25 20:35 == 34.8	4/17/25 1:05 == 48.1	4/17/25 5:35 == 48.2	4/17/25 10:05 == 34.6
4/16/25 20:40 == 34.8	4/17/25 1:10 == 45.5	4/17/25 5:40 == 47.8	4/17/25 10:10 == 34.6
4/16/25 20:45 == 34.9	4/17/25 1:15 == 37.9	4/17/25 5:45 == 47.8	4/17/25 10:15 == 34.4
4/16/25 20:50 == 34.9	4/17/25 1:20 == 34.5	4/17/25 5:50 == 47.9	4/17/25 10:20 == 34.5
4/16/25 20:55 == 34.9	4/17/25 1:25 == 34.5	4/17/25 5:55 == 48	4/17/25 10:25 == 35.2
4/16/25 21:00 == 35.1	4/17/25 1:30 == 34.5	4/17/25 6:00 == 47.9	4/17/25 10:30 == 42.8
4/16/25 21:05 == 35.2	4/17/25 1:35 == 34.4	4/17/25 6:05 == 47.9	4/17/25 10:35 == 47.9
4/16/25 21:10 == 36.9	4/17/25 1:40 == 34.8	4/17/25 6:10 == 46	4/17/25 10:40 == 47.7
4/16/25 21:15 == 43.7	4/17/25 1:45 == 35.1	4/17/25 6:15 == 37.6	4/17/25 10:45 == 47.5
4/16/25 21:20 == 48	4/17/25 1:50 == 35	4/17/25 6:20 == 34.4	4/17/25 10:50 == 47.9
4/16/25 21:25 == 48	4/17/25 1:55 == 35.1	4/17/25 6:25 == 34.7	4/17/25 10:55 == 48.1
4/16/25 21:30 == 47.5	4/17/25 2:00 == 35.1	4/17/25 6:30 == 34.8	4/17/25 11:00 == 48.1
4/16/25 21:35 == 48	4/17/25 2:05 == 34.9	4/17/25 6:35 == 34.8	4/17/25 11:05 == 48.1
4/16/25 21:40 == 48	4/17/25 2:10 == 36.8	4/17/25 6:40 == 34.8	4/17/25 11:10 == 47.6
4/16/25 21:45 == 47.9	4/17/25 2:15 == 43.1	4/17/25 6:45 == 34.7	4/17/25 11:15 == 47.8
4/16/25 21:50 == 48	4/17/25 2:20 == 47.7	4/17/25 6:50 == 34.7	4/17/25 11:20 == 47.8
4/16/25 21:55 == 48.2	4/17/25 2:25 == 48	4/17/25 6:55 == 36.7	4/17/25 11:25 == 48
4/16/25 22:00 == 48.2	4/17/25 2:30 == 48.2	4/17/25 7:00 == 42.9	4/17/25 11:30 == 47.9
4/16/25 22:05 == 47.9	4/17/25 2:35 == 48.1	4/17/25 7:05 == 48	4/17/25 11:35 == 47.9
4/16/25 22:10 == 47.9	4/17/25 2:40 == 47.8	4/17/25 7:10 == 47.6	4/17/25 11:40 == 47.5
4/16/25 22:15 == 48	4/17/25 2:45 == 48.1	4/17/25 7:15 == 47.5	4/17/25 11:45 == 47.7
4/16/25 22:20 == 47.8	4/17/25 2:50 == 48	4/17/25 7:20 == 47.9	4/17/25 11:50 == 48
4/16/25 22:25 == 45.1	4/17/25 2:55 == 47.8	4/17/25 7:25 == 48	4/17/25 11:55 == 47.8

Pumpback Station Discharge (0364)

4/17/25 12:00 == 47.7	4/17/25 16:30 == 48	4/17/25 21:00 == 48.1	4/18/25 1:30 == 47.9
4/17/25 12:05 == 47.9	4/17/25 16:35 == 48	4/17/25 21:05 == 47.8	4/18/25 1:35 == 47.9
4/17/25 12:10 == 47.7	4/17/25 16:40 == 48	4/17/25 21:10 == 47.2	4/18/25 1:40 == 47.8
4/17/25 12:15 == 47.6	4/17/25 16:45 == 48	4/17/25 21:15 == 47.8	4/18/25 1:45 == 47.3
4/17/25 12:20 == 48	4/17/25 16:50 == 47.9	4/17/25 21:20 == 47.8	4/18/25 1:50 == 48
4/17/25 12:25 == 46	4/17/25 16:55 == 47.9	4/17/25 21:25 == 48	4/18/25 1:55 == 48.2
4/17/25 12:30 == 39.4	4/17/25 17:00 == 47.9	4/17/25 21:30 == 37.9	4/18/25 2:00 == 47.8
4/17/25 12:35 == 34.6	4/17/25 17:05 == 47.9	4/17/25 21:35 == 34.3	4/18/25 2:05 == 47.9
4/17/25 12:40 == 34.5	4/17/25 17:10 == 47.6	4/17/25 21:40 == 34	4/18/25 2:10 == 48
4/17/25 12:45 == 34.4	4/17/25 17:15 == 47.6	4/17/25 21:45 == 33.9	4/18/25 2:15 == 48
4/17/25 12:50 == 34.3	4/17/25 17:20 == 47.9	4/17/25 21:50 == 34	4/18/25 2:20 == 48.1
4/17/25 12:55 == 34.4	4/17/25 17:25 == 48.1	4/17/25 21:55 == 34	4/18/25 2:25 == 48.1
4/17/25 13:00 == 34.2	4/17/25 17:30 == 48.1	4/17/25 22:00 == 34	4/18/25 2:30 == 38.8
4/17/25 13:05 == 34.2	4/17/25 17:35 == 47.9	4/17/25 22:05 == 34	4/18/25 2:35 == 34.6
4/17/25 13:10 == 34.3	4/17/25 17:40 == 46.1	4/17/25 22:10 == 34	4/18/25 2:40 == 34.2
4/17/25 13:15 == 41.6	4/17/25 17:45 == 39.4	4/17/25 22:15 == 40.7	4/18/25 2:45 == 34.1
4/17/25 13:20 == 47.6	4/17/25 17:50 == 34	4/17/25 22:20 == 47.7	4/18/25 2:50 == 34.1
4/17/25 13:25 == 47.5	4/17/25 17:55 == 34	4/17/25 22:25 == 48	4/18/25 2:55 == 34.1
4/17/25 13:30 == 47.2	4/17/25 18:00 == 34	4/17/25 22:30 == 48.2	4/18/25 3:00 == 34
4/17/25 13:35 == 47.7	4/17/25 18:05 == 34.1	4/17/25 22:35 == 48	4/18/25 3:05 == 34
4/17/25 13:40 == 48	4/17/25 18:10 == 34.2	4/17/25 22:40 == 47.9	4/18/25 3:10 == 34
4/17/25 13:45 == 48.2	4/17/25 18:15 == 33.7	4/17/25 22:45 == 47.9	4/18/25 3:15 == 40.6
4/17/25 13:50 == 48.1	4/17/25 18:20 == 33.8	4/17/25 22:50 == 48.1	4/18/25 3:20 == 47
4/17/25 13:55 == 47.9	4/17/25 18:25 == 33.8	4/17/25 22:55 == 48.1	4/18/25 3:25 == 47.9
4/17/25 14:00 == 47.7	4/17/25 18:30 == 33.8	4/17/25 23:00 == 48	4/18/25 3:30 == 47.6
4/17/25 14:05 == 47.8	4/17/25 18:35 == 33.8	4/17/25 23:05 == 47.9	4/18/25 3:35 == 47.6
4/17/25 14:10 == 48	4/17/25 18:40 == 33.9	4/17/25 23:10 == 48	4/18/25 3:40 == 47.8
4/17/25 14:15 == 47.9	4/17/25 18:45 == 42	4/17/25 23:15 == 47.8	4/18/25 3:45 == 47.6
4/17/25 14:20 == 47.9	4/17/25 18:50 == 46.9	4/17/25 23:20 == 47.5	4/18/25 3:50 == 47.8
4/17/25 14:25 == 47.6	4/17/25 18:55 == 48	4/17/25 23:25 == 48.1	4/18/25 3:55 == 48.1
4/17/25 14:30 == 47.5	4/17/25 19:00 == 48.2	4/17/25 23:30 == 48	4/18/25 4:00 == 48.1
4/17/25 14:35 == 48	4/17/25 19:05 == 48.1	4/17/25 23:35 == 48.1	4/18/25 4:05 == 48
4/17/25 14:40 == 45.5	4/17/25 19:10 == 48.1	4/17/25 23:40 == 47.9	4/18/25 4:10 == 48
4/17/25 14:45 == 38.6	4/17/25 19:15 == 48	4/17/25 23:45 == 48	4/18/25 4:15 == 48
4/17/25 14:50 == 33.9	4/17/25 19:20 == 48	4/17/25 23:50 == 47.8	4/18/25 4:20 == 48
4/17/25 14:55 == 34	4/17/25 19:25 == 47.9	4/17/25 23:55 == 48	4/18/25 4:25 == 48
4/17/25 15:00 == 33.9	4/17/25 19:30 == 47.9	4/18/25 0:00 == 38.5	4/18/25 4:30 == 48
4/17/25 15:05 == 33.8	4/17/25 19:35 == 48	4/18/25 0:05 == 34.4	4/18/25 4:35 == 48
4/17/25 15:10 == 34	4/17/25 19:40 == 47.7	4/18/25 0:10 == 33.8	4/18/25 4:40 == 48.1
4/17/25 15:15 == 33.9	4/17/25 19:45 == 47.7	4/18/25 0:15 == 33.8	4/18/25 4:45 == 47.8
4/17/25 15:20 == 33.9	4/17/25 19:50 == 47.9	4/18/25 0:20 == 33.8	4/18/25 4:50 == 47.8
4/17/25 15:25 == 34	4/17/25 19:55 == 48	4/18/25 0:25 == 33.8	4/18/25 4:55 == 47.9
4/17/25 15:30 == 34.1	4/17/25 20:00 == 47.8	4/18/25 0:30 == 33.8	4/18/25 5:00 == 47.8
4/17/25 15:35 == 34.2	4/17/25 20:05 == 47.5	4/18/25 0:35 == 33.9	4/18/25 5:05 == 48.2
4/17/25 15:40 == 34.5	4/17/25 20:10 == 47.6	4/18/25 0:40 == 33.9	4/18/25 5:10 == 48.1
4/17/25 15:45 == 41.8	4/17/25 20:15 == 47.8	4/18/25 0:45 == 40.4	4/18/25 5:15 == 48
4/17/25 15:50 == 47.5	4/17/25 20:20 == 48	4/18/25 0:50 == 47.1	4/18/25 5:20 == 48
4/17/25 15:55 == 47.8	4/17/25 20:25 == 47.8	4/18/25 0:55 == 47.9	4/18/25 5:25 == 48.1
4/17/25 16:00 == 47.9	4/17/25 20:30 == 47.2	4/18/25 1:00 == 47.8	4/18/25 5:30 == 39.3
4/17/25 16:05 == 47.8	4/17/25 20:35 == 48	4/18/25 1:05 == 47.8	4/18/25 5:35 == 34.3
4/17/25 16:10 == 47.5	4/17/25 20:40 == 48.2	4/18/25 1:10 == 47.9	4/18/25 5:40 == 33.8
4/17/25 16:15 == 47.9	4/17/25 20:45 == 48	4/18/25 1:15 == 47.9	4/18/25 5:45 == 33.8
4/17/25 16:20 == 47.9	4/17/25 20:50 == 48.1	4/18/25 1:20 == 48	4/18/25 5:50 == 33.9
4/17/25 16:25 == 48	4/17/25 20:55 == 48.1	4/18/25 1:25 == 48.1	4/18/25 5:55 == 33.8

Pumpback Station Discharge (0364)

4/18/25 6:00 == 33.8	4/18/25 10:30 == 39.6	4/18/25 15:00 == 47.7	4/18/25 19:30 == 33.8
4/18/25 6:05 == 33.8	4/18/25 10:35 == 34.7	4/18/25 15:05 == 47.9	4/18/25 19:35 == 33.9
4/18/25 6:10 == 33.9	4/18/25 10:40 == 34.4	4/18/25 15:10 == 48	4/18/25 19:40 == 34.2
4/18/25 6:15 == 39.2	4/18/25 10:45 == 34.6	4/18/25 15:15 == 48.1	4/18/25 19:45 == 36.6
4/18/25 6:20 == 47.7	4/18/25 10:50 == 34.4	4/18/25 15:20 == 48.1	4/18/25 19:50 == 47.6
4/18/25 6:25 == 47.8	4/18/25 10:55 == 34.3	4/18/25 15:25 == 47.9	4/18/25 19:55 == 48
4/18/25 6:30 == 47.5	4/18/25 11:00 == 34.4	4/18/25 15:30 == 48	4/18/25 20:00 == 47.9
4/18/25 6:35 == 47.8	4/18/25 11:05 == 34.4	4/18/25 15:35 == 47.9	4/18/25 20:05 == 48
4/18/25 6:40 == 48	4/18/25 11:10 == 34.7	4/18/25 15:40 == 47.9	4/18/25 20:10 == 47.4
4/18/25 6:45 == 47.9	4/18/25 11:15 == 40	4/18/25 15:45 == 48	4/18/25 20:15 == 48
4/18/25 6:50 == 48.1	4/18/25 11:20 == 46.8	4/18/25 15:50 == 48	4/18/25 20:20 == 47.9
4/18/25 6:55 == 48.1	4/18/25 11:25 == 47.9	4/18/25 15:55 == 47.5	4/18/25 20:25 == 47.2
4/18/25 7:00 == 48	4/18/25 11:30 == 48	4/18/25 16:00 == 47.8	4/18/25 20:30 == 47.5
4/18/25 7:05 == 48.1	4/18/25 11:35 == 48.1	4/18/25 16:05 == 48	4/18/25 20:35 == 47.9
4/18/25 7:10 == 47.6	4/18/25 11:40 == 48	4/18/25 16:10 == 47.7	4/18/25 20:40 == 48
4/18/25 7:15 == 47.4	4/18/25 11:45 == 47.6	4/18/25 16:15 == 47.5	4/18/25 20:45 == 48
4/18/25 7:20 == 47.4	4/18/25 11:50 == 48	4/18/25 16:20 == 47.7	4/18/25 20:50 == 48
4/18/25 7:25 == 48	4/18/25 11:55 == 47.7	4/18/25 16:25 == 47.9	4/18/25 20:55 == 47.9
4/18/25 7:30 == 48	4/18/25 12:00 == 47.3	4/18/25 16:30 == 42.1	4/18/25 21:00 == 48
4/18/25 7:35 == 48	4/18/25 12:05 == 47.9	4/18/25 16:35 == 34	4/18/25 21:05 == 48.1
4/18/25 7:40 == 48	4/18/25 12:10 == 47.5	4/18/25 16:40 == 33.8	4/18/25 21:10 == 47.7
4/18/25 7:45 == 39.8	4/18/25 12:15 == 47.9	4/18/25 16:45 == 33.8	4/18/25 21:15 == 47.7
4/18/25 7:50 == 35	4/18/25 12:20 == 47.5	4/18/25 16:50 == 33.8	4/18/25 21:20 == 48
4/18/25 7:55 == 34.1	4/18/25 12:25 == 48.1	4/18/25 16:55 == 34.1	4/18/25 21:25 == 47.6
4/18/25 8:00 == 34.1	4/18/25 12:30 == 47.4	4/18/25 17:00 == 34.2	4/18/25 21:30 == 47.6
4/18/25 8:05 == 34.1	4/18/25 12:35 == 47.9	4/18/25 17:05 == 34.1	4/18/25 21:35 == 47.9
4/18/25 8:10 == 34	4/18/25 12:40 == 48.2	4/18/25 17:10 == 34.5	4/18/25 21:40 == 48
4/18/25 8:15 == 34	4/18/25 12:45 == 48	4/18/25 17:15 == 37.3	4/18/25 21:45 == 42.7
4/18/25 8:20 == 34	4/18/25 12:50 == 47.9	4/18/25 17:20 == 47.5	4/18/25 21:50 == 34.2
4/18/25 8:25 == 34	4/18/25 12:55 == 47.9	4/18/25 17:25 == 47.9	4/18/25 21:55 == 34
4/18/25 8:30 == 39.5	4/18/25 13:00 == 47.7	4/18/25 17:30 == 48	4/18/25 22:00 == 34.1
4/18/25 8:35 == 46.2	4/18/25 13:05 == 47.8	4/18/25 17:35 == 47.9	4/18/25 22:05 == 34
4/18/25 8:40 == 48.1	4/18/25 13:10 == 48	4/18/25 17:40 == 48.2	4/18/25 22:10 == 34
4/18/25 8:45 == 48	4/18/25 13:15 == 48.1	4/18/25 17:45 == 47.9	4/18/25 22:15 == 33.9
4/18/25 8:50 == 48.1	4/18/25 13:20 == 48	4/18/25 17:50 == 48.1	4/18/25 22:20 == 34
4/18/25 8:55 == 48.2	4/18/25 13:25 == 47.5	4/18/25 17:55 == 47.9	4/18/25 22:25 == 34.2
4/18/25 9:00 == 48.1	4/18/25 13:30 == 40.4	4/18/25 18:00 == 48	4/18/25 22:30 == 36
4/18/25 9:05 == 48.1	4/18/25 13:35 == 34.7	4/18/25 18:05 == 48	4/18/25 22:35 == 47.6
4/18/25 9:10 == 48.1	4/18/25 13:40 == 34.1	4/18/25 18:10 == 47.6	4/18/25 22:40 == 47.4
4/18/25 9:15 == 47.9	4/18/25 13:45 == 34.2	4/18/25 18:15 == 47.9	4/18/25 22:45 == 47.3
4/18/25 9:20 == 47.9	4/18/25 13:50 == 34.2	4/18/25 18:20 == 48.2	4/18/25 22:50 == 48.1
4/18/25 9:25 == 47.8	4/18/25 13:55 == 34.2	4/18/25 18:25 == 48.1	4/18/25 22:55 == 47.9
4/18/25 9:30 == 48.1	4/18/25 14:00 == 34.3	4/18/25 18:30 == 47.6	4/18/25 23:00 == 48
4/18/25 9:35 == 48	4/18/25 14:05 == 34.2	4/18/25 18:35 == 47.7	4/18/25 23:05 == 47.8
4/18/25 9:40 == 46.9	4/18/25 14:10 == 34.1	4/18/25 18:40 == 47.6	4/18/25 23:10 == 48
4/18/25 9:45 == 47.6	4/18/25 14:15 == 34	4/18/25 18:45 == 47.5	4/18/25 23:15 == 48.1
4/18/25 9:50 == 48.1	4/18/25 14:20 == 34.1	4/18/25 18:50 == 47.8	4/18/25 23:20 == 48
4/18/25 9:55 == 48	4/18/25 14:25 == 34.4	4/18/25 18:55 == 47.9	4/18/25 23:25 == 48
4/18/25 10:00 == 48	4/18/25 14:30 == 37.5	4/18/25 19:00 == 41.9	4/18/25 23:30 == 48
4/18/25 10:05 == 48.2	4/18/25 14:35 == 47.6	4/18/25 19:05 == 34.4	4/18/25 23:35 == 47.9
4/18/25 10:10 == 48	4/18/25 14:40 == 47.7	4/18/25 19:10 == 33.9	4/18/25 23:40 == 47.9
4/18/25 10:15 == 48.1	4/18/25 14:45 == 47	4/18/25 19:15 == 33.8	4/18/25 23:45 == 47.9
4/18/25 10:20 == 48.1	4/18/25 14:50 == 47.9	4/18/25 19:20 == 33.8	4/18/25 23:50 == 48
4/18/25 10:25 == 47.6	4/18/25 14:55 == 47.7	4/18/25 19:25 == 33.9	4/18/25 23:55 == 48

Pumpback Station Discharge (0364)

4/19/25 0:00 == 48	4/19/25 4:30 == 48	4/19/25 9:00 == 47.9	4/19/25 13:30 == 33.9
4/19/25 0:05 == 48	4/19/25 4:35 == 48.1	4/19/25 9:05 == 48.1	4/19/25 13:35 == 33.8
4/19/25 0:10 == 48	4/19/25 4:40 == 48	4/19/25 9:10 == 48	4/19/25 13:40 == 33.8
4/19/25 0:15 == 42.8	4/19/25 4:45 == 48.1	4/19/25 9:15 == 48.1	4/19/25 13:45 == 34.1
4/19/25 0:20 == 34.9	4/19/25 4:50 == 48	4/19/25 9:20 == 48.1	4/19/25 13:50 == 34.1
4/19/25 0:25 == 33.9	4/19/25 4:55 == 47.9	4/19/25 9:25 == 48	4/19/25 13:55 == 34.1
4/19/25 0:30 == 34	4/19/25 5:00 == 47.9	4/19/25 9:30 == 48	4/19/25 14:00 == 34.9
4/19/25 0:35 == 34	4/19/25 5:05 == 48	4/19/25 9:35 == 47.5	4/19/25 14:05 == 46.2
4/19/25 0:40 == 34	4/19/25 5:10 == 48	4/19/25 9:40 == 47.5	4/19/25 14:10 == 47.8
4/19/25 0:45 == 34	4/19/25 5:15 == 42.6	4/19/25 9:45 == 42.9	4/19/25 14:15 == 48.1
4/19/25 0:50 == 33.9	4/19/25 5:20 == 35.5	4/19/25 9:50 == 36.1	4/19/25 14:20 == 48
4/19/25 0:55 == 34	4/19/25 5:25 == 33.8	4/19/25 9:55 == 33.9	4/19/25 14:25 == 47.3
4/19/25 1:00 == 35.7	4/19/25 5:30 == 33.8	4/19/25 10:00 == 34	4/19/25 14:30 == 47.7
4/19/25 1:05 == 47.5	4/19/25 5:35 == 33.9	4/19/25 10:05 == 34	4/19/25 14:35 == 47.9
4/19/25 1:10 == 48	4/19/25 5:40 == 34	4/19/25 10:10 == 34	4/19/25 14:40 == 47.4
4/19/25 1:15 == 47.7	4/19/25 5:45 == 34	4/19/25 10:15 == 34	4/19/25 14:45 == 47.8
4/19/25 1:20 == 48.1	4/19/25 5:50 == 33.9	4/19/25 10:20 == 34	4/19/25 14:50 == 47.9
4/19/25 1:25 == 47.9	4/19/25 5:55 == 33.9	4/19/25 10:25 == 34	4/19/25 14:55 == 48
4/19/25 1:30 == 47.9	4/19/25 6:00 == 35.9	4/19/25 10:30 == 34	4/19/25 15:00 == 48
4/19/25 1:35 == 47.9	4/19/25 6:05 == 46.5	4/19/25 10:35 == 33.9	4/19/25 15:05 == 48
4/19/25 1:40 == 47.4	4/19/25 6:10 == 47.9	4/19/25 10:40 == 34.2	4/19/25 15:10 == 48
4/19/25 1:45 == 47.7	4/19/25 6:15 == 47.9	4/19/25 10:45 == 37.7	4/19/25 15:15 == 48.1
4/19/25 1:50 == 48	4/19/25 6:20 == 48	4/19/25 10:50 == 44.7	4/19/25 15:20 == 47.9
4/19/25 1:55 == 47.4	4/19/25 6:25 == 47.8	4/19/25 10:55 == 47.8	4/19/25 15:25 == 47.5
4/19/25 2:00 == 47.7	4/19/25 6:30 == 47.8	4/19/25 11:00 == 48	4/19/25 15:30 == 43.3
4/19/25 2:05 == 47.9	4/19/25 6:35 == 48	4/19/25 11:05 == 47.9	4/19/25 15:35 == 36.9
4/19/25 2:10 == 47.9	4/19/25 6:40 == 48.1	4/19/25 11:10 == 47.8	4/19/25 15:40 == 34.5
4/19/25 2:15 == 48	4/19/25 6:45 == 48.1	4/19/25 11:15 == 47.2	4/19/25 15:45 == 34.6
4/19/25 2:20 == 48.1	4/19/25 6:50 == 48.1	4/19/25 11:20 == 47.9	4/19/25 15:50 == 34.6
4/19/25 2:25 == 48	4/19/25 6:55 == 47.7	4/19/25 11:25 == 48	4/19/25 15:55 == 34.7
4/19/25 2:30 == 48.1	4/19/25 7:00 == 47.8	4/19/25 11:30 == 48.2	4/19/25 16:00 == 34.6
4/19/25 2:35 == 48.1	4/19/25 7:05 == 48	4/19/25 11:35 == 47.9	4/19/25 16:05 == 34.5
4/19/25 2:40 == 48	4/19/25 7:10 == 47.6	4/19/25 11:40 == 47.7	4/19/25 16:10 == 34.5
4/19/25 2:45 == 42.5	4/19/25 7:15 == 47.9	4/19/25 11:45 == 47.8	4/19/25 16:15 == 36.1
4/19/25 2:50 == 35	4/19/25 7:20 == 47.9	4/19/25 11:50 == 48.1	4/19/25 16:20 == 44.6
4/19/25 2:55 == 33.9	4/19/25 7:25 == 48	4/19/25 11:55 == 47.8	4/19/25 16:25 == 47.8
4/19/25 3:00 == 33.9	4/19/25 7:30 == 43	4/19/25 12:00 == 47.6	4/19/25 16:30 == 47.3
4/19/25 3:05 == 34	4/19/25 7:35 == 36.7	4/19/25 12:05 == 47.4	4/19/25 16:35 == 48.1
4/19/25 3:10 == 33.9	4/19/25 7:40 == 34.4	4/19/25 12:10 == 47.7	4/19/25 16:40 == 47.9
4/19/25 3:15 == 33.9	4/19/25 7:45 == 34.3	4/19/25 12:15 == 47.9	4/19/25 16:45 == 48
4/19/25 3:20 == 33.9	4/19/25 7:50 == 34.3	4/19/25 12:20 == 47.9	4/19/25 16:50 == 48.1
4/19/25 3:25 == 33.9	4/19/25 7:55 == 34.3	4/19/25 12:25 == 47.7	4/19/25 16:55 == 47.7
4/19/25 3:30 == 35.7	4/19/25 8:00 == 34.2	4/19/25 12:30 == 47.8	4/19/25 17:00 == 47.7
4/19/25 3:35 == 47	4/19/25 8:05 == 34.3	4/19/25 12:35 == 48	4/19/25 17:05 == 48
4/19/25 3:40 == 47.6	4/19/25 8:10 == 34.2	4/19/25 12:40 == 48	4/19/25 17:10 == 47.6
4/19/25 3:45 == 47.4	4/19/25 8:15 == 36.8	4/19/25 12:45 == 47.9	4/19/25 17:15 == 47.7
4/19/25 3:50 == 48	4/19/25 8:20 == 44.6	4/19/25 12:50 == 48	4/19/25 17:20 == 48.1
4/19/25 3:55 == 47.9	4/19/25 8:25 == 47.7	4/19/25 12:55 == 48	4/19/25 17:25 == 48
4/19/25 4:00 == 48.1	4/19/25 8:30 == 47.6	4/19/25 13:00 == 47.8	4/19/25 17:30 == 48
4/19/25 4:05 == 48.1	4/19/25 8:35 == 47.9	4/19/25 13:05 == 47.9	4/19/25 17:35 == 48
4/19/25 4:10 == 47.5	4/19/25 8:40 == 48	4/19/25 13:10 == 48	4/19/25 17:40 == 48
4/19/25 4:15 == 47.8	4/19/25 8:45 == 47.4	4/19/25 13:15 == 43.8	4/19/25 17:45 == 43.8
4/19/25 4:20 == 47.9	4/19/25 8:50 == 48	4/19/25 13:20 == 35.7	4/19/25 17:50 == 37.3
4/19/25 4:25 == 48	4/19/25 8:55 == 48.1	4/19/25 13:25 == 33.8	4/19/25 17:55 == 34.5

Pumpback Station Discharge (0364)

4/19/25 18:00 == 34.5	4/19/25 22:30 == 48.1	4/20/25 3:00 == 47.5	4/20/25 7:30 == 48
4/19/25 18:05 == 34.4	4/19/25 22:35 == 48	4/20/25 3:05 == 47.9	4/20/25 7:35 == 47.9
4/19/25 18:10 == 34.3	4/19/25 22:40 == 47.6	4/20/25 3:10 == 47.9	4/20/25 7:40 == 47.9
4/19/25 18:15 == 34.2	4/19/25 22:45 == 48	4/20/25 3:15 == 47.8	4/20/25 7:45 == 47.9
4/19/25 18:20 == 34.1	4/19/25 22:50 == 48	4/20/25 3:20 == 48.1	4/20/25 7:50 == 47.9
4/19/25 18:25 == 34.1	4/19/25 22:55 == 48	4/20/25 3:25 == 48	4/20/25 7:55 == 47.7
4/19/25 18:30 == 34.1	4/19/25 23:00 == 48	4/20/25 3:30 == 48.1	4/20/25 8:00 == 47.8
4/19/25 18:35 == 34	4/19/25 23:05 == 48	4/20/25 3:35 == 48	4/20/25 8:05 == 48
4/19/25 18:40 == 34.2	4/19/25 23:10 == 48	4/20/25 3:40 == 47.5	4/20/25 8:10 == 47.9
4/19/25 18:45 == 36.5	4/19/25 23:15 == 44.1	4/20/25 3:45 == 45.4	4/20/25 8:15 == 48
4/19/25 18:50 == 44.6	4/19/25 23:20 == 37.4	4/20/25 3:50 == 36.7	4/20/25 8:20 == 35.7
4/19/25 18:55 == 48	4/19/25 23:25 == 33.9	4/20/25 3:55 == 33.7	4/20/25 8:25 == 34
4/19/25 19:00 == 48	4/19/25 23:30 == 33.7	4/20/25 4:00 == 33.7	4/20/25 8:30 == 33.8
4/19/25 19:05 == 47.8	4/19/25 23:35 == 33.8	4/20/25 4:05 == 33.8	4/20/25 8:35 == 33.6
4/19/25 19:10 == 48	4/19/25 23:40 == 33.9	4/20/25 4:10 == 33.9	4/20/25 8:40 == 33.8
4/19/25 19:15 == 48	4/19/25 23:45 == 33.7	4/20/25 4:15 == 34	4/20/25 8:45 == 34.1
4/19/25 19:20 == 47.9	4/19/25 23:50 == 33.7	4/20/25 4:20 == 33.9	4/20/25 8:50 == 33.8
4/19/25 19:25 == 48.1	4/19/25 23:55 == 33.7	4/20/25 4:25 == 33.9	4/20/25 8:55 == 33.8
4/19/25 19:30 == 47.9	4/20/25 0:00 == 35.5	4/20/25 4:30 == 35.7	4/20/25 9:00 == 33.8
4/19/25 19:35 == 48	4/20/25 0:05 == 43.5	4/20/25 4:35 == 41.9	4/20/25 9:05 == 33.7
4/19/25 19:40 == 47.5	4/20/25 0:10 == 47.8	4/20/25 4:40 == 47.5	4/20/25 9:10 == 33.7
4/19/25 19:45 == 47.6	4/20/25 0:15 == 47.9	4/20/25 4:45 == 47.7	4/20/25 9:15 == 34.6
4/19/25 19:50 == 48.1	4/20/25 0:20 == 48.1	4/20/25 4:50 == 47.9	4/20/25 9:20 == 42.5
4/19/25 19:55 == 48.2	4/20/25 0:25 == 47.8	4/20/25 4:55 == 48	4/20/25 9:25 == 47.8
4/19/25 20:00 == 48.1	4/20/25 0:30 == 47.5	4/20/25 5:00 == 48	4/20/25 9:30 == 48
4/19/25 20:05 == 48	4/20/25 0:35 == 48	4/20/25 5:05 == 47.9	4/20/25 9:35 == 48.1
4/19/25 20:10 == 47.7	4/20/25 0:40 == 48.2	4/20/25 5:10 == 48	4/20/25 9:40 == 47.8
4/19/25 20:15 == 47.9	4/20/25 0:45 == 48	4/20/25 5:15 == 48.2	4/20/25 9:45 == 47.7
4/19/25 20:20 == 48	4/20/25 0:50 == 48.2	4/20/25 5:20 == 48.1	4/20/25 9:50 == 48.1
4/19/25 20:25 == 47.6	4/20/25 0:55 == 48.1	4/20/25 5:25 == 48.1	4/20/25 9:55 == 48.1
4/19/25 20:30 == 47.7	4/20/25 1:00 == 47.9	4/20/25 5:30 == 47.9	4/20/25 10:00 == 47.9
4/19/25 20:35 == 48.1	4/20/25 1:05 == 47.9	4/20/25 5:35 == 47.8	4/20/25 10:05 == 48.1
4/19/25 20:40 == 48	4/20/25 1:10 == 47.4	4/20/25 5:40 == 47.7	4/20/25 10:10 == 48.1
4/19/25 20:45 == 44.2	4/20/25 1:15 == 45	4/20/25 5:45 == 47.6	4/20/25 10:15 == 48.1
4/19/25 20:50 == 37.6	4/20/25 1:20 == 37	4/20/25 5:50 == 47.9	4/20/25 10:20 == 48.1
4/19/25 20:55 == 34.3	4/20/25 1:25 == 34	4/20/25 5:55 == 48	4/20/25 10:25 == 48.1
4/19/25 21:00 == 34.2	4/20/25 1:30 == 34	4/20/25 6:00 == 48	4/20/25 10:30 == 48
4/19/25 21:05 == 34.3	4/20/25 1:35 == 34	4/20/25 6:05 == 47.9	4/20/25 10:35 == 48.1
4/19/25 21:10 == 34.4	4/20/25 1:40 == 34.2	4/20/25 6:10 == 47.6	4/20/25 10:40 == 48
4/19/25 21:15 == 34.3	4/20/25 1:45 == 34.4	4/20/25 6:15 == 45.9	4/20/25 10:45 == 47.2
4/19/25 21:20 == 34.3	4/20/25 1:50 == 34.4	4/20/25 6:20 == 36.8	4/20/25 10:50 == 36.6
4/19/25 21:25 == 34.2	4/20/25 1:55 == 34.5	4/20/25 6:25 == 34.2	4/20/25 10:55 == 34
4/19/25 21:30 == 35.8	4/20/25 2:00 == 36.8	4/20/25 6:30 == 34.3	4/20/25 11:00 == 34.2
4/19/25 21:35 == 44.2	4/20/25 2:05 == 42.8	4/20/25 6:35 == 34.1	4/20/25 11:05 == 34.2
4/19/25 21:40 == 47.9	4/20/25 2:10 == 47.6	4/20/25 6:40 == 34.2	4/20/25 11:10 == 34.3
4/19/25 21:45 == 47.8	4/20/25 2:15 == 48	4/20/25 6:45 == 34.2	4/20/25 11:15 == 34.2
4/19/25 21:50 == 48.2	4/20/25 2:20 == 48	4/20/25 6:50 == 34.2	4/20/25 11:20 == 34.1
4/19/25 21:55 == 48.3	4/20/25 2:25 == 48.1	4/20/25 6:55 == 34.3	4/20/25 11:25 == 34.1
4/19/25 22:00 == 47.9	4/20/25 2:30 == 47.9	4/20/25 7:00 == 34.5	4/20/25 11:30 == 34.3
4/19/25 22:05 == 48	4/20/25 2:35 == 47.7	4/20/25 7:05 == 34.3	4/20/25 11:35 == 43
4/19/25 22:10 == 47.5	4/20/25 2:40 == 48	4/20/25 7:10 == 34.3	4/20/25 11:40 == 47.2
4/19/25 22:15 == 47.7	4/20/25 2:45 == 47.9	4/20/25 7:15 == 36.3	4/20/25 11:45 == 47.9
4/19/25 22:20 == 48	4/20/25 2:50 == 48.1	4/20/25 7:20 == 42.3	4/20/25 11:50 == 47.6
4/19/25 22:25 == 48	4/20/25 2:55 == 47.8	4/20/25 7:25 == 48	4/20/25 11:55 == 47.4

Pumpback Station Discharge (0364)

4/20/25 12:00 == 47.6	4/20/25 16:30 == 47.8	4/20/25 21:00 == 48.2	4/21/25 1:30 == 47.9
4/20/25 12:05 == 47.8	4/20/25 16:35 == 37.2	4/20/25 21:05 == 48.1	4/21/25 1:35 == 48
4/20/25 12:10 == 48	4/20/25 16:40 == 34	4/20/25 21:10 == 47.6	4/21/25 1:40 == 48
4/20/25 12:15 == 48	4/20/25 16:45 == 33.9	4/20/25 21:15 == 47.5	4/21/25 1:45 == 47.4
4/20/25 12:20 == 48	4/20/25 16:50 == 33.8	4/20/25 21:20 == 37.6	4/21/25 1:50 == 47.9
4/20/25 12:25 == 47.8	4/20/25 16:55 == 34	4/20/25 21:25 == 34.4	4/21/25 1:55 == 48
4/20/25 12:30 == 47.7	4/20/25 17:00 == 34.1	4/20/25 21:30 == 33.9	4/21/25 2:00 == 47
4/20/25 12:35 == 48	4/20/25 17:05 == 34.1	4/20/25 21:35 == 34	4/21/25 2:05 == 39.5
4/20/25 12:40 == 48.1	4/20/25 17:10 == 34.3	4/20/25 21:40 == 33.9	4/21/25 2:10 == 34.2
4/20/25 12:45 == 48	4/20/25 17:15 == 34.2	4/20/25 21:45 == 33.9	4/21/25 2:15 == 33.9
4/20/25 12:50 == 47.8	4/20/25 17:20 == 34.1	4/20/25 21:50 == 34	4/21/25 2:20 == 34.2
4/20/25 12:55 == 47.4	4/20/25 17:25 == 34.2	4/20/25 21:55 == 34.1	4/21/25 2:25 == 34
4/20/25 13:00 == 47.7	4/20/25 17:30 == 35.3	4/20/25 22:00 == 34.1	4/21/25 2:30 == 34
4/20/25 13:05 == 48.1	4/20/25 17:35 == 41	4/20/25 22:05 == 34	4/21/25 2:35 == 34.2
4/20/25 13:10 == 48.1	4/20/25 17:40 == 47.7	4/20/25 22:10 == 34	4/21/25 2:40 == 34.1
4/20/25 13:15 == 48.1	4/20/25 17:45 == 47.9	4/20/25 22:15 == 33.9	4/21/25 2:45 == 33.9
4/20/25 13:20 == 47.4	4/20/25 17:50 == 47.9	4/20/25 22:20 == 41.2	4/21/25 2:50 == 34
4/20/25 13:25 == 47.7	4/20/25 17:55 == 48	4/20/25 22:25 == 47.6	4/21/25 2:55 == 33.9
4/20/25 13:30 == 47.6	4/20/25 18:00 == 48	4/20/25 22:30 == 47.9	4/21/25 3:00 == 33.9
4/20/25 13:35 == 48	4/20/25 18:05 == 48	4/20/25 22:35 == 48	4/21/25 3:05 == 41.2
4/20/25 13:40 == 47.9	4/20/25 18:10 == 47.8	4/20/25 22:40 == 47.8	4/21/25 3:10 == 46.6
4/20/25 13:45 == 48.1	4/20/25 18:15 == 47.6	4/20/25 22:45 == 47.6	4/21/25 3:15 == 47.9
4/20/25 13:50 == 36.2	4/20/25 18:20 == 48.1	4/20/25 22:50 == 48.1	4/21/25 3:20 == 48
4/20/25 13:55 == 34	4/20/25 18:25 == 48	4/20/25 22:55 == 48.2	4/21/25 3:25 == 48
4/20/25 14:00 == 34.1	4/20/25 18:30 == 48	4/20/25 23:00 == 48	4/21/25 3:30 == 48
4/20/25 14:05 == 34.1	4/20/25 18:35 == 48.2	4/20/25 23:05 == 48.2	4/21/25 3:35 == 48
4/20/25 14:10 == 34.1	4/20/25 18:40 == 48.2	4/20/25 23:10 == 48	4/21/25 3:40 == 47.8
4/20/25 14:15 == 34.1	4/20/25 18:45 == 48.1	4/20/25 23:15 == 47.9	4/21/25 3:45 == 47.6
4/20/25 14:20 == 34.2	4/20/25 18:50 == 37	4/20/25 23:20 == 48	4/21/25 3:50 == 47.9
4/20/25 14:25 == 34	4/20/25 18:55 == 34.2	4/20/25 23:25 == 47.9	4/21/25 3:55 == 48
4/20/25 14:30 == 33.8	4/20/25 19:00 == 33.8	4/20/25 23:30 == 47.9	4/21/25 4:00 == 48
4/20/25 14:35 == 34	4/20/25 19:05 == 33.8	4/20/25 23:35 == 48.1	4/21/25 4:05 == 48
4/20/25 14:40 == 34.2	4/20/25 19:10 == 33.8	4/20/25 23:40 == 47.9	4/21/25 4:10 == 48
4/20/25 14:45 == 35.5	4/20/25 19:15 == 33.8	4/20/25 23:45 == 48.1	4/21/25 4:15 == 48
4/20/25 14:50 == 41.5	4/20/25 19:20 == 33.6	4/20/25 23:50 == 48	4/21/25 4:20 == 48
4/20/25 14:55 == 47.4	4/20/25 19:25 == 33.4	4/20/25 23:55 == 48.1	4/21/25 4:25 == 48
4/20/25 15:00 == 47.7	4/20/25 19:30 == 33.5	4/21/25 0:00 == 48.1	4/21/25 4:30 == 46.5
4/20/25 15:05 == 48.1	4/20/25 19:35 == 41.7	4/21/25 0:05 == 37.9	4/21/25 4:35 == 40
4/20/25 15:10 == 48.1	4/20/25 19:40 == 47	4/21/25 0:10 == 34	4/21/25 4:40 == 33.7
4/20/25 15:15 == 48	4/20/25 19:45 == 47.6	4/21/25 0:15 == 33.6	4/21/25 4:45 == 33.5
4/20/25 15:20 == 48.1	4/20/25 19:50 == 47.9	4/21/25 0:20 == 33.5	4/21/25 4:50 == 33.6
4/20/25 15:25 == 47.9	4/20/25 19:55 == 47.9	4/21/25 0:25 == 33.7	4/21/25 4:55 == 33.7
4/20/25 15:30 == 47.2	4/20/25 20:00 == 48	4/21/25 0:30 == 33.9	4/21/25 5:00 == 33.5
4/20/25 15:35 == 48	4/20/25 20:05 == 48.1	4/21/25 0:35 == 33.8	4/21/25 5:05 == 33.6
4/20/25 15:40 == 48.1	4/20/25 20:10 == 47.9	4/21/25 0:40 == 33.8	4/21/25 5:10 == 33.6
4/20/25 15:45 == 48	4/20/25 20:15 == 47.6	4/21/25 0:45 == 33.9	4/21/25 5:15 == 33.6
4/20/25 15:50 == 48	4/20/25 20:20 == 47.9	4/21/25 0:50 == 40.8	4/21/25 5:20 == 40.6
4/20/25 15:55 == 47.9	4/20/25 20:25 == 47.7	4/21/25 0:55 == 47	4/21/25 5:25 == 46.4
4/20/25 16:00 == 47.4	4/20/25 20:30 == 47.4	4/21/25 1:00 == 48	4/21/25 5:30 == 47.3
4/20/25 16:05 == 47.9	4/20/25 20:35 == 48	4/21/25 1:05 == 48	4/21/25 5:35 == 47.7
4/20/25 16:10 == 47.5	4/20/25 20:40 == 47.9	4/21/25 1:10 == 48.1	4/21/25 5:40 == 47.4
4/20/25 16:15 == 47.7	4/20/25 20:45 == 47.7	4/21/25 1:15 == 48.1	4/21/25 5:45 == 47.8
4/20/25 16:20 == 48	4/20/25 20:50 == 48.1	4/21/25 1:20 == 48	4/21/25 5:50 == 48
4/20/25 16:25 == 47.8	4/20/25 20:55 == 48.2	4/21/25 1:25 == 48	4/21/25 5:55 == 47.9

Pumpback Station Discharge (0364)

4/21/25 6:00 == 48	4/21/25 10:30 == 48.1	4/21/25 15:00 == 47.8	4/21/25 19:30 == 33.7
4/21/25 6:05 == 47.9	4/21/25 10:35 == 48	4/21/25 15:05 == 47.4	4/21/25 19:35 == 37.5
4/21/25 6:10 == 48.1	4/21/25 10:40 == 47.5	4/21/25 15:10 == 48.1	4/21/25 19:40 == 46.6
4/21/25 6:15 == 47.9	4/21/25 10:45 == 47.7	4/21/25 15:15 == 48.1	4/21/25 19:45 == 47.3
4/21/25 6:20 == 47.8	4/21/25 10:50 == 47.8	4/21/25 15:20 == 47.9	4/21/25 19:50 == 47.9
4/21/25 6:25 == 48.1	4/21/25 10:55 == 47.5	4/21/25 15:25 == 47.9	4/21/25 19:55 == 48
4/21/25 6:30 == 48.1	4/21/25 11:00 == 47.7	4/21/25 15:30 == 48	4/21/25 20:00 == 47.9
4/21/25 6:35 == 48	4/21/25 11:05 == 40.4	4/21/25 15:35 == 47.9	4/21/25 20:05 == 48.1
4/21/25 6:40 == 48	4/21/25 11:10 == 35	4/21/25 15:40 == 48	4/21/25 20:10 == 48
4/21/25 6:45 == 46.8	4/21/25 11:15 == 34.4	4/21/25 15:45 == 48.2	4/21/25 20:15 == 47.2
4/21/25 6:50 == 41.2	4/21/25 11:20 == 34.3	4/21/25 15:50 == 48	4/21/25 20:20 == 48
4/21/25 6:55 == 34.3	4/21/25 11:25 == 34.5	4/21/25 15:55 == 48.1	4/21/25 20:25 == 48
4/21/25 7:00 == 34.3	4/21/25 11:30 == 34.6	4/21/25 16:00 == 48	4/21/25 20:30 == 47.6
4/21/25 7:05 == 34.4	4/21/25 11:35 == 34.5	4/21/25 16:05 == 48	4/21/25 20:35 == 48.1
4/21/25 7:10 == 34.6	4/21/25 11:40 == 34.6	4/21/25 16:10 == 47.5	4/21/25 20:40 == 47.9
4/21/25 7:15 == 34.4	4/21/25 11:45 == 34.8	4/21/25 16:15 == 47.4	4/21/25 20:45 == 48
4/21/25 7:20 == 34.3	4/21/25 11:50 == 34.7	4/21/25 16:20 == 40.7	4/21/25 20:50 == 48.1
4/21/25 7:25 == 34.4	4/21/25 11:55 == 34.7	4/21/25 16:25 == 34.8	4/21/25 20:55 == 48
4/21/25 7:30 == 34.4	4/21/25 12:00 == 34.7	4/21/25 16:30 == 34	4/21/25 21:00 == 48
4/21/25 7:35 == 34.3	4/21/25 12:05 == 38.2	4/21/25 16:35 == 33.9	4/21/25 21:05 == 41.1
4/21/25 7:40 == 34.6	4/21/25 12:10 == 47.7	4/21/25 16:40 == 33.9	4/21/25 21:10 == 35.7
4/21/25 7:45 == 34.2	4/21/25 12:15 == 48.1	4/21/25 16:45 == 33.9	4/21/25 21:15 == 34.3
4/21/25 7:50 == 41	4/21/25 12:20 == 48	4/21/25 16:50 == 33.9	4/21/25 21:20 == 34.2
4/21/25 7:55 == 47	4/21/25 12:25 == 47.9	4/21/25 16:55 == 34.1	4/21/25 21:25 == 34.3
4/21/25 8:00 == 48.1	4/21/25 12:30 == 47.8	4/21/25 17:00 == 34.3	4/21/25 21:30 == 34.4
4/21/25 8:05 == 48	4/21/25 12:35 == 48.1	4/21/25 17:05 == 34.2	4/21/25 21:35 == 34.3
4/21/25 8:10 == 47.8	4/21/25 12:40 == 47.8	4/21/25 17:10 == 34.5	4/21/25 21:40 == 34.3
4/21/25 8:15 == 47.9	4/21/25 12:45 == 47.5	4/21/25 17:15 == 35	4/21/25 21:45 == 34.3
4/21/25 8:20 == 48.1	4/21/25 12:50 == 48	4/21/25 17:20 == 37.7	4/21/25 21:50 == 34.4
4/21/25 8:25 == 47.9	4/21/25 12:55 == 47.9	4/21/25 17:25 == 47.6	4/21/25 21:55 == 34.4
4/21/25 8:30 == 47.4	4/21/25 13:00 == 48	4/21/25 17:30 == 48	4/21/25 22:00 == 34.3
4/21/25 8:35 == 47.8	4/21/25 13:05 == 48	4/21/25 17:35 == 47.8	4/21/25 22:05 == 38.1
4/21/25 8:40 == 47.8	4/21/25 13:10 == 48.1	4/21/25 17:40 == 47.9	4/21/25 22:10 == 46.5
4/21/25 8:45 == 47.7	4/21/25 13:15 == 48.1	4/21/25 17:45 == 48	4/21/25 22:15 == 47.8
4/21/25 8:50 == 47.9	4/21/25 13:20 == 48	4/21/25 17:50 == 48.1	4/21/25 22:20 == 48
4/21/25 8:55 == 48.1	4/21/25 13:25 == 47.4	4/21/25 17:55 == 47.9	4/21/25 22:25 == 48
4/21/25 9:00 == 46.9	4/21/25 13:30 == 47.7	4/21/25 18:00 == 48.1	4/21/25 22:30 == 47.9
4/21/25 9:05 == 41	4/21/25 13:35 == 48	4/21/25 18:05 == 48.1	4/21/25 22:35 == 48
4/21/25 9:10 == 33.7	4/21/25 13:40 == 47.9	4/21/25 18:10 == 47.5	4/21/25 22:40 == 48.1
4/21/25 9:15 == 33.7	4/21/25 13:45 == 48	4/21/25 18:15 == 47.8	4/21/25 22:45 == 48
4/21/25 9:20 == 33.8	4/21/25 13:50 == 40.9	4/21/25 18:20 == 48	4/21/25 22:50 == 48
4/21/25 9:25 == 33.8	4/21/25 13:55 == 34.4	4/21/25 18:25 == 47.9	4/21/25 22:55 == 48.1
4/21/25 9:30 == 33.8	4/21/25 14:00 == 34.2	4/21/25 18:30 == 48.1	4/21/25 23:00 == 47.9
4/21/25 9:35 == 33.8	4/21/25 14:05 == 34.3	4/21/25 18:35 == 48.1	4/21/25 23:05 == 48.2
4/21/25 9:40 == 33.9	4/21/25 14:10 == 34.3	4/21/25 18:40 == 47.6	4/21/25 23:10 == 48
4/21/25 9:45 == 34.4	4/21/25 14:15 == 34.2	4/21/25 18:45 == 47.8	4/21/25 23:15 == 47.9
4/21/25 9:50 == 38.9	4/21/25 14:20 == 34.3	4/21/25 18:50 == 41	4/21/25 23:20 == 48.1
4/21/25 9:55 == 47.8	4/21/25 14:25 == 34.3	4/21/25 18:55 == 35	4/21/25 23:25 == 48.1
4/21/25 10:00 == 47.9	4/21/25 14:30 == 34.3	4/21/25 19:00 == 34.1	4/21/25 23:30 == 47.9
4/21/25 10:05 == 48.1	4/21/25 14:35 == 34.1	4/21/25 19:05 == 34.1	4/21/25 23:35 == 47.8
4/21/25 10:10 == 47.8	4/21/25 14:40 == 34.2	4/21/25 19:10 == 34	4/21/25 23:40 == 47.8
4/21/25 10:15 == 48.2	4/21/25 14:45 == 34.6	4/21/25 19:15 == 34	4/21/25 23:45 == 47.9
4/21/25 10:20 == 48.1	4/21/25 14:50 == 38.1	4/21/25 19:20 == 33.9	4/21/25 23:50 == 47.9
4/21/25 10:25 == 48	4/21/25 14:55 == 47.6	4/21/25 19:25 == 33.8	4/21/25 23:55 == 47.9

Pumpback Station Discharge (0364)

4/22/25 0:00 == 47.9	4/22/25 4:30 == 48.1	4/22/25 9:00 == 48	4/22/25 13:30 == 34.6
4/22/25 0:05 == 41.8	4/22/25 4:35 == 48.1	4/22/25 9:05 == 48.1	4/22/25 13:35 == 34.4
4/22/25 0:10 == 35.4	4/22/25 4:40 == 48	4/22/25 9:10 == 48.1	4/22/25 13:40 == 34.6
4/22/25 0:15 == 34	4/22/25 4:45 == 48.1	4/22/25 9:15 == 48	4/22/25 13:45 == 34.7
4/22/25 0:20 == 33.9	4/22/25 4:50 == 42.3	4/22/25 9:20 == 48	4/22/25 13:50 == 36.8
4/22/25 0:25 == 34	4/22/25 4:55 == 35.6	4/22/25 9:25 == 47.8	4/22/25 13:55 == 45.4
4/22/25 0:30 == 34.1	4/22/25 5:00 == 33.6	4/22/25 9:30 == 47.9	4/22/25 14:00 == 47.7
4/22/25 0:35 == 34	4/22/25 5:05 == 33.8	4/22/25 9:35 == 43.4	4/22/25 14:05 == 47.9
4/22/25 0:40 == 34	4/22/25 5:10 == 33.8	4/22/25 9:40 == 35.7	4/22/25 14:10 == 47.9
4/22/25 0:45 == 34.1	4/22/25 5:15 == 33.8	4/22/25 9:45 == 34.4	4/22/25 14:15 == 47.9
4/22/25 0:50 == 34.1	4/22/25 5:20 == 33.9	4/22/25 9:50 == 34.5	4/22/25 14:20 == 47.9
4/22/25 0:55 == 34	4/22/25 5:25 == 33.9	4/22/25 9:55 == 34.4	4/22/25 14:25 == 47.6
4/22/25 1:00 == 34	4/22/25 5:30 == 33.8	4/22/25 10:00 == 34.3	4/22/25 14:30 == 47.5
4/22/25 1:05 == 36.2	4/22/25 5:35 == 33.7	4/22/25 10:05 == 34.4	4/22/25 14:35 == 48
4/22/25 1:10 == 47.4	4/22/25 5:40 == 33.9	4/22/25 10:10 == 34.5	4/22/25 14:40 == 47.7
4/22/25 1:15 == 47.9	4/22/25 5:45 == 34.2	4/22/25 10:15 == 34.5	4/22/25 14:45 == 47.8
4/22/25 1:20 == 48.1	4/22/25 5:50 == 37.4	4/22/25 10:20 == 34.5	4/22/25 14:50 == 48
4/22/25 1:25 == 47.9	4/22/25 5:55 == 45.7	4/22/25 10:25 == 34.4	4/22/25 14:55 == 47.9
4/22/25 1:30 == 48.1	4/22/25 6:00 == 47.8	4/22/25 10:30 == 34.4	4/22/25 15:00 == 47.9
4/22/25 1:35 == 48.2	4/22/25 6:05 == 48.1	4/22/25 10:35 == 38.2	4/22/25 15:05 == 47.9
4/22/25 1:40 == 47.7	4/22/25 6:10 == 48.1	4/22/25 10:40 == 44.5	4/22/25 15:10 == 47.9
4/22/25 1:45 == 47.6	4/22/25 6:15 == 48	4/22/25 10:45 == 47.4	4/22/25 15:15 == 48
4/22/25 1:50 == 47.8	4/22/25 6:20 == 48	4/22/25 10:50 == 48	4/22/25 15:20 == 43.5
4/22/25 1:55 == 47.5	4/22/25 6:25 == 48	4/22/25 10:55 == 48	4/22/25 15:25 == 37.2
4/22/25 2:00 == 47.8	4/22/25 6:30 == 47.2	4/22/25 11:00 == 48	4/22/25 15:30 == 34.7
4/22/25 2:05 == 48	4/22/25 6:35 == 48.1	4/22/25 11:05 == 47.9	4/22/25 15:35 == 34.7
4/22/25 2:10 == 48	4/22/25 6:40 == 48.2	4/22/25 11:10 == 47.8	4/22/25 15:40 == 34.6
4/22/25 2:15 == 48.1	4/22/25 6:45 == 47.8	4/22/25 11:15 == 47.3	4/22/25 15:45 == 34.5
4/22/25 2:20 == 48.1	4/22/25 6:50 == 47.8	4/22/25 11:20 == 47.9	4/22/25 15:50 == 34.5
4/22/25 2:25 == 48	4/22/25 6:55 == 48	4/22/25 11:25 == 47.9	4/22/25 15:55 == 34.6
4/22/25 2:30 == 48.1	4/22/25 7:00 == 48	4/22/25 11:30 == 48.1	4/22/25 16:00 == 34.6
4/22/25 2:35 == 48.1	4/22/25 7:05 == 47.6	4/22/25 11:35 == 48.1	4/22/25 16:05 == 37.3
4/22/25 2:40 == 47.9	4/22/25 7:10 == 47.4	4/22/25 11:40 == 47.9	4/22/25 16:10 == 44.4
4/22/25 2:45 == 48	4/22/25 7:15 == 47.7	4/22/25 11:45 == 47.4	4/22/25 16:15 == 47.7
4/22/25 2:50 == 42.4	4/22/25 7:20 == 42.5	4/22/25 11:50 == 47.9	4/22/25 16:20 == 48.1
4/22/25 2:55 == 35.4	4/22/25 7:25 == 36.2	4/22/25 11:55 == 47.8	4/22/25 16:25 == 48
4/22/25 3:00 == 34.3	4/22/25 7:30 == 34.5	4/22/25 12:00 == 47.3	4/22/25 16:30 == 48
4/22/25 3:05 == 34.2	4/22/25 7:35 == 34.5	4/22/25 12:05 == 47.3	4/22/25 16:35 == 48.2
4/22/25 3:10 == 34.1	4/22/25 7:40 == 34.4	4/22/25 12:10 == 47.3	4/22/25 16:40 == 48.1
4/22/25 3:15 == 34.1	4/22/25 7:45 == 34.4	4/22/25 12:15 == 47.6	4/22/25 16:45 == 47.9
4/22/25 3:20 == 34.1	4/22/25 7:50 == 34.5	4/22/25 12:20 == 47.9	4/22/25 16:50 == 47.9
4/22/25 3:25 == 33.9	4/22/25 7:55 == 34.6	4/22/25 12:25 == 48	4/22/25 16:55 == 47.6
4/22/25 3:30 == 33.8	4/22/25 8:00 == 34.6	4/22/25 12:30 == 48	4/22/25 17:00 == 47.2
4/22/25 3:35 == 36.2	4/22/25 8:05 == 34.5	4/22/25 12:35 == 48	4/22/25 17:05 == 47.8
4/22/25 3:40 == 47	4/22/25 8:10 == 34.5	4/22/25 12:40 == 47.9	4/22/25 17:10 == 47.7
4/22/25 3:45 == 47.9	4/22/25 8:15 == 34.2	4/22/25 12:45 == 48.1	4/22/25 17:15 == 47.4
4/22/25 3:50 == 48.1	4/22/25 8:20 == 37.5	4/22/25 12:50 == 47.8	4/22/25 17:20 == 47.9
4/22/25 3:55 == 47.9	4/22/25 8:25 == 45.3	4/22/25 12:55 == 47.8	4/22/25 17:25 == 47.9
4/22/25 4:00 == 47.9	4/22/25 8:30 == 48.1	4/22/25 13:00 == 48	4/22/25 17:30 == 48
4/22/25 4:05 == 47.8	4/22/25 8:35 == 48.1	4/22/25 13:05 == 43.3	4/22/25 17:35 == 47.9
4/22/25 4:10 == 48	4/22/25 8:40 == 47.9	4/22/25 13:10 == 36.6	4/22/25 17:40 == 47.4
4/22/25 4:15 == 47.6	4/22/25 8:45 == 47.4	4/22/25 13:15 == 34.2	4/22/25 17:45 == 47.7
4/22/25 4:20 == 48.2	4/22/25 8:50 == 48.1	4/22/25 13:20 == 34	4/22/25 17:50 == 43.7
4/22/25 4:25 == 48	4/22/25 8:55 == 48.1	4/22/25 13:25 == 34.3	4/22/25 17:55 == 36.9

Pumpback Station Discharge (0364)

4/22/25 18:00 == 34.4	4/22/25 22:30 == 47.8	4/23/25 3:00 == 47	4/23/25 7:30 == 34.4
4/22/25 18:05 == 34.5	4/22/25 22:35 == 48.2	4/23/25 3:05 == 47.8	4/23/25 7:35 == 34.5
4/22/25 18:10 == 34.3	4/22/25 22:40 == 47.4	4/23/25 3:10 == 48	4/23/25 7:40 == 34.4
4/22/25 18:15 == 34.2	4/22/25 22:45 == 47.6	4/23/25 3:15 == 48	4/23/25 7:45 == 34.4
4/22/25 18:20 == 34.2	4/22/25 22:50 == 48	4/23/25 3:20 == 47.5	4/23/25 7:50 == 36
4/22/25 18:25 == 34.1	4/22/25 22:55 == 47.9	4/23/25 3:25 == 47.8	4/23/25 7:55 == 42.8
4/22/25 18:30 == 34.1	4/22/25 23:00 == 47.8	4/23/25 3:30 == 48	4/23/25 8:00 == 47.2
4/22/25 18:35 == 36.9	4/22/25 23:05 == 44.1	4/23/25 3:35 == 48.1	4/23/25 8:05 == 47.6
4/22/25 18:40 == 43.8	4/22/25 23:10 == 37.4	4/23/25 3:40 == 47.4	4/23/25 8:10 == 48
4/22/25 18:45 == 47.7	4/22/25 23:15 == 34.2	4/23/25 3:45 == 47.8	4/23/25 8:15 == 48
4/22/25 18:50 == 48	4/22/25 23:20 == 34.2	4/23/25 3:50 == 47.9	4/23/25 8:20 == 47.9
4/22/25 18:55 == 48	4/22/25 23:25 == 34.2	4/23/25 3:55 == 47.9	4/23/25 8:25 == 48.1
4/22/25 19:00 == 48.1	4/22/25 23:30 == 34.2	4/23/25 4:00 == 47.9	4/23/25 8:30 == 47.9
4/22/25 19:05 == 48.1	4/22/25 23:35 == 34.2	4/23/25 4:05 == 48	4/23/25 8:35 == 48
4/22/25 19:10 == 48.1	4/22/25 23:40 == 34.1	4/23/25 4:10 == 47.7	4/23/25 8:40 == 47.9
4/22/25 19:15 == 47.9	4/22/25 23:45 == 34	4/23/25 4:15 == 47.7	4/23/25 8:45 == 48
4/22/25 19:20 == 48	4/22/25 23:50 == 36.4	4/23/25 4:20 == 44.7	4/23/25 8:50 == 48
4/22/25 19:25 == 47.8	4/22/25 23:55 == 43.4	4/23/25 4:25 == 37.9	4/23/25 8:55 == 47.9
4/22/25 19:30 == 48	4/23/25 0:00 == 47.6	4/23/25 4:30 == 34	4/23/25 9:00 == 47.9
4/22/25 19:35 == 48	4/23/25 0:05 == 47.9	4/23/25 4:35 == 34	4/23/25 9:05 == 46.1
4/22/25 19:40 == 47.4	4/23/25 0:10 == 48.1	4/23/25 4:40 == 34	4/23/25 9:10 == 37.1
4/22/25 19:45 == 47.8	4/23/25 0:15 == 48	4/23/25 4:45 == 33.9	4/23/25 9:15 == 33.8
4/22/25 19:50 == 48	4/23/25 0:20 == 48.1	4/23/25 4:50 == 33.8	4/23/25 9:20 == 33.8
4/22/25 19:55 == 47.8	4/23/25 0:25 == 47.9	4/23/25 4:55 == 33.9	4/23/25 9:25 == 33.8
4/22/25 20:00 == 48.1	4/23/25 0:30 == 47.3	4/23/25 5:00 == 33.9	4/23/25 9:30 == 33.8
4/22/25 20:05 == 47.9	4/23/25 0:35 == 48.1	4/23/25 5:05 == 35.9	4/23/25 9:35 == 33.9
4/22/25 20:10 == 48	4/23/25 0:40 == 47.9	4/23/25 5:10 == 42.5	4/23/25 9:40 == 34
4/22/25 20:15 == 47.6	4/23/25 0:45 == 47.9	4/23/25 5:15 == 47.6	4/23/25 9:45 == 34
4/22/25 20:20 == 44	4/23/25 0:50 == 48	4/23/25 5:20 == 47.9	4/23/25 9:50 == 33.9
4/22/25 20:25 == 37.3	4/23/25 0:55 == 48.1	4/23/25 5:25 == 47.9	4/23/25 9:55 == 34
4/22/25 20:30 == 34.5	4/23/25 1:00 == 48	4/23/25 5:30 == 47.4	4/23/25 10:00 == 34
4/22/25 20:35 == 34.4	4/23/25 1:05 == 48	4/23/25 5:35 == 47.9	4/23/25 10:05 == 35.9
4/22/25 20:40 == 34.4	4/23/25 1:10 == 48.1	4/23/25 5:40 == 48	4/23/25 10:10 == 42.1
4/22/25 20:45 == 34.3	4/23/25 1:15 == 48.1	4/23/25 5:45 == 47.6	4/23/25 10:15 == 47.7
4/22/25 20:50 == 34.4	4/23/25 1:20 == 47.9	4/23/25 5:50 == 48.1	4/23/25 10:20 == 48
4/22/25 20:55 == 34.5	4/23/25 1:25 == 48	4/23/25 5:55 == 47.8	4/23/25 10:25 == 47.9
4/22/25 21:00 == 34.5	4/23/25 1:30 == 48	4/23/25 6:00 == 47.8	4/23/25 10:30 == 47.8
4/22/25 21:05 == 37.2	4/23/25 1:35 == 47.9	4/23/25 6:05 == 48	4/23/25 10:35 == 48
4/22/25 21:10 == 43.5	4/23/25 1:40 == 47.5	4/23/25 6:10 == 48	4/23/25 10:40 == 48.1
4/22/25 21:15 == 47.5	4/23/25 1:45 == 47.5	4/23/25 6:15 == 48.2	4/23/25 10:45 == 47
4/22/25 21:20 == 47.8	4/23/25 1:50 == 44.1	4/23/25 6:20 == 48.1	4/23/25 10:50 == 48.1
4/22/25 21:25 == 47.7	4/23/25 1:55 == 37.8	4/23/25 6:25 == 47.6	4/23/25 10:55 == 48.2
4/22/25 21:30 == 47.5	4/23/25 2:00 == 34.5	4/23/25 6:30 == 47.8	4/23/25 11:00 == 48.1
4/22/25 21:35 == 48.1	4/23/25 2:05 == 34.3	4/23/25 6:35 == 48	4/23/25 11:05 == 48
4/22/25 21:40 == 47.9	4/23/25 2:10 == 34.4	4/23/25 6:40 == 48	4/23/25 11:10 == 47.7
4/22/25 21:45 == 47.6	4/23/25 2:15 == 34.4	4/23/25 6:45 == 48	4/23/25 11:15 == 47.6
4/22/25 21:50 == 48.1	4/23/25 2:20 == 34.2	4/23/25 6:50 == 48	4/23/25 11:20 == 47.9
4/22/25 21:55 == 48	4/23/25 2:25 == 34.3	4/23/25 6:55 == 47.8	4/23/25 11:25 == 48.1
4/22/25 22:00 == 47.9	4/23/25 2:30 == 34.5	4/23/25 7:00 == 47.9	4/23/25 11:30 == 47.9
4/22/25 22:05 == 48.1	4/23/25 2:35 == 36.6	4/23/25 7:05 == 44.8	4/23/25 11:35 == 48.1
4/22/25 22:10 == 48	4/23/25 2:40 == 43.5	4/23/25 7:10 == 38.4	4/23/25 11:40 == 47.6
4/22/25 22:15 == 47.8	4/23/25 2:45 == 47.6	4/23/25 7:15 == 34.7	4/23/25 11:45 == 47.7
4/22/25 22:20 == 48	4/23/25 2:50 == 47.9	4/23/25 7:20 == 34.5	4/23/25 11:50 == 47.9
4/22/25 22:25 == 47.6	4/23/25 2:55 == 47.8	4/23/25 7:25 == 34.5	4/23/25 11:55 == 48

Pumpback Station Discharge (0364)

4/23/25 12:00 == 48	4/23/25 16:30 == 34.2	4/23/25 21:00 == 48.1	4/24/25 1:30 == 48
4/23/25 12:05 == 48	4/23/25 16:35 == 34	4/23/25 21:05 == 47.8	4/24/25 1:35 == 46.4
4/23/25 12:10 == 47.6	4/23/25 16:40 == 34	4/23/25 21:10 == 47.8	4/24/25 1:40 == 40.3
4/23/25 12:15 == 47.6	4/23/25 16:45 == 33.9	4/23/25 21:15 == 46.9	4/24/25 1:45 == 34.5
4/23/25 12:20 == 47.9	4/23/25 16:50 == 33.9	4/23/25 21:20 == 47.9	4/24/25 1:50 == 34.3
4/23/25 12:25 == 47.7	4/23/25 16:55 == 34.1	4/23/25 21:25 == 47.7	4/24/25 1:55 == 34.3
4/23/25 12:30 == 47.4	4/23/25 17:00 == 34.3	4/23/25 21:30 == 47.8	4/24/25 2:00 == 34.3
4/23/25 12:35 == 47.6	4/23/25 17:05 == 34.2	4/23/25 21:35 == 47.8	4/24/25 2:05 == 34.3
4/23/25 12:40 == 48	4/23/25 17:10 == 41.9	4/23/25 21:40 == 48	4/24/25 2:10 == 34.3
4/23/25 12:45 == 47.9	4/23/25 17:15 == 47.5	4/23/25 21:45 == 48	4/24/25 2:15 == 34.2
4/23/25 12:50 == 47.9	4/23/25 17:20 == 48	4/23/25 21:50 == 48.1	4/24/25 2:20 == 34.3
4/23/25 12:55 == 48	4/23/25 17:25 == 48	4/23/25 21:55 == 47.6	4/24/25 2:25 == 41.1
4/23/25 13:00 == 48.2	4/23/25 17:30 == 47.8	4/23/25 22:00 == 47.7	4/24/25 2:30 == 47.6
4/23/25 13:05 == 48.2	4/23/25 17:35 == 47.9	4/23/25 22:05 == 47.9	4/24/25 2:35 == 48
4/23/25 13:10 == 47.9	4/23/25 17:40 == 48	4/23/25 22:10 == 47.9	4/24/25 2:40 == 47.8
4/23/25 13:15 == 48	4/23/25 17:45 == 48	4/23/25 22:15 == 47.9	4/24/25 2:45 == 47.6
4/23/25 13:20 == 48.1	4/23/25 17:50 == 48.1	4/23/25 22:20 == 47.9	4/24/25 2:50 == 47.9
4/23/25 13:25 == 47.9	4/23/25 17:55 == 48	4/23/25 22:25 == 48	4/24/25 2:55 == 47.4
4/23/25 13:30 == 47.1	4/23/25 18:00 == 48	4/23/25 22:30 == 47.9	4/24/25 3:00 == 48
4/23/25 13:35 == 48	4/23/25 18:05 == 48.1	4/23/25 22:35 == 46.1	4/24/25 3:05 == 48
4/23/25 13:40 == 35.9	4/23/25 18:10 == 47.9	4/23/25 22:40 == 39.5	4/24/25 3:10 == 47.9
4/23/25 13:45 == 34.3	4/23/25 18:15 == 47.2	4/23/25 22:45 == 34	4/24/25 3:15 == 47.9
4/23/25 13:50 == 34.3	4/23/25 18:20 == 47.5	4/23/25 22:50 == 34.1	4/24/25 3:20 == 47.8
4/23/25 13:55 == 34.2	4/23/25 18:25 == 47.8	4/23/25 22:55 == 34.1	4/24/25 3:25 == 47.6
4/23/25 14:00 == 34.4	4/23/25 18:30 == 47.8	4/23/25 23:00 == 33.9	4/24/25 3:30 == 47.8
4/23/25 14:05 == 34.3	4/23/25 18:35 == 48.1	4/23/25 23:05 == 34	4/24/25 3:35 == 48
4/23/25 14:10 == 34.3	4/23/25 18:40 == 47.9	4/23/25 23:10 == 34.1	4/24/25 3:40 == 47.7
4/23/25 14:15 == 34.3	4/23/25 18:45 == 47.5	4/23/25 23:15 == 34	4/24/25 3:45 == 47.6
4/23/25 14:20 == 34.1	4/23/25 18:50 == 48.1	4/23/25 23:20 == 35.2	4/24/25 3:50 == 47.8
4/23/25 14:25 == 43	4/23/25 18:55 == 48.1	4/23/25 23:25 == 40.5	4/24/25 3:55 == 47.9
4/23/25 14:30 == 47.6	4/23/25 19:00 == 48	4/23/25 23:30 == 47.5	4/24/25 4:00 == 48
4/23/25 14:35 == 47.9	4/23/25 19:05 == 47.9	4/23/25 23:35 == 48.1	4/24/25 4:05 == 47.9
4/23/25 14:40 == 47.6	4/23/25 19:10 == 47.9	4/23/25 23:40 == 47.8	4/24/25 4:10 == 47.7
4/23/25 14:45 == 47.8	4/23/25 19:15 == 47.9	4/23/25 23:45 == 48	4/24/25 4:15 == 47.5
4/23/25 14:50 == 48	4/23/25 19:20 == 47.4	4/23/25 23:50 == 47.9	4/24/25 4:20 == 48.2
4/23/25 14:55 == 48	4/23/25 19:25 == 37.5	4/23/25 23:55 == 47.9	4/24/25 4:25 == 48
4/23/25 15:00 == 48	4/23/25 19:30 == 33.8	4/24/25 0:00 == 48	4/24/25 4:30 == 47.8
4/23/25 15:05 == 48	4/23/25 19:35 == 33.7	4/24/25 0:05 == 48	4/24/25 4:35 == 46.8
4/23/25 15:10 == 47.9	4/23/25 19:40 == 33.9	4/24/25 0:10 == 47.9	4/24/25 4:40 == 40
4/23/25 15:15 == 47.8	4/23/25 19:45 == 33.9	4/24/25 0:15 == 48	4/24/25 4:45 == 33.8
4/23/25 15:20 == 47.9	4/23/25 19:50 == 33.8	4/24/25 0:20 == 48.1	4/24/25 4:50 == 33.8
4/23/25 15:25 == 48	4/23/25 19:55 == 33.8	4/24/25 0:25 == 47.9	4/24/25 4:55 == 33.9
4/23/25 15:30 == 48	4/23/25 20:00 == 33.9	4/24/25 0:30 == 47.9	4/24/25 5:00 == 33.8
4/23/25 15:35 == 47.8	4/23/25 20:05 == 34.9	4/24/25 0:35 == 47.9	4/24/25 5:05 == 33.9
4/23/25 15:40 == 48	4/23/25 20:10 == 41	4/24/25 0:40 == 47.9	4/24/25 5:10 == 33.8
4/23/25 15:45 == 47.9	4/23/25 20:15 == 47.4	4/24/25 0:45 == 47.6	4/24/25 5:15 == 33.8
4/23/25 15:50 == 48.1	4/23/25 20:20 == 47.5	4/24/25 0:50 == 47.7	4/24/25 5:20 == 33.8
4/23/25 15:55 == 47.9	4/23/25 20:25 == 47.7	4/24/25 0:55 == 48	4/24/25 5:25 == 41.2
4/23/25 16:00 == 47.7	4/23/25 20:30 == 47.6	4/24/25 1:00 == 48.1	4/24/25 5:30 == 46.7
4/23/25 16:05 == 48	4/23/25 20:35 == 47.9	4/24/25 1:05 == 47.7	4/24/25 5:35 == 47.9
4/23/25 16:10 == 47.7	4/23/25 20:40 == 48.1	4/24/25 1:10 == 47.5	4/24/25 5:40 == 47.4
4/23/25 16:15 == 47.1	4/23/25 20:45 == 48	4/24/25 1:15 == 47.8	4/24/25 5:45 == 47.8
4/23/25 16:20 == 47.9	4/23/25 20:50 == 48.1	4/24/25 1:20 == 48	4/24/25 5:50 == 47.9
4/23/25 16:25 == 36.7	4/23/25 20:55 == 48.2	4/24/25 1:25 == 48	4/24/25 5:55 == 47.4

Pumpback Station Discharge (0364)

4/24/25 6:00 == 47.7	4/24/25 10:30 == 33.5	4/24/25 15:00 == 48.1	4/24/25 19:30 == 33.4
4/24/25 6:05 == 47.9	4/24/25 10:35 == 33.4	4/24/25 15:05 == 48.1	4/24/25 19:35 == 33.4
4/24/25 6:10 == 47.9	4/24/25 10:40 == 33.7	4/24/25 15:10 == 48.1	4/24/25 19:40 == 33.4
4/24/25 6:15 == 47.9	4/24/25 10:45 == 33.6	4/24/25 15:15 == 47.8	4/24/25 19:45 == 33.5
4/24/25 6:20 == 48	4/24/25 10:50 == 33.6	4/24/25 15:20 == 48.2	4/24/25 19:50 == 33.6
4/24/25 6:25 == 48	4/24/25 10:55 == 40.6	4/24/25 15:25 == 47.9	4/24/25 19:55 == 37
4/24/25 6:30 == 47.8	4/24/25 11:00 == 46.4	4/24/25 15:30 == 48.1	4/24/25 20:00 == 47.5
4/24/25 6:35 == 47.8	4/24/25 11:05 == 47.9	4/24/25 15:35 == 47.9	4/24/25 20:05 == 47.9
4/24/25 6:40 == 48	4/24/25 11:10 == 47.6	4/24/25 15:40 == 47.8	4/24/25 20:10 == 47.5
4/24/25 6:45 == 48.1	4/24/25 11:15 == 47.7	4/24/25 15:45 == 48	4/24/25 20:15 == 47.9
4/24/25 6:50 == 48.1	4/24/25 11:20 == 48	4/24/25 15:50 == 47.9	4/24/25 20:20 == 48.1
4/24/25 6:55 == 48	4/24/25 11:25 == 47.8	4/24/25 15:55 == 48	4/24/25 20:25 == 48.1
4/24/25 7:00 == 47.6	4/24/25 11:30 == 47.8	4/24/25 16:00 == 48.1	4/24/25 20:30 == 47.3
4/24/25 7:05 == 47.9	4/24/25 11:35 == 47.8	4/24/25 16:05 == 48	4/24/25 20:35 == 48
4/24/25 7:10 == 48	4/24/25 11:40 == 47.6	4/24/25 16:10 == 47.4	4/24/25 20:40 == 48
4/24/25 7:15 == 47.6	4/24/25 11:45 == 47.6	4/24/25 16:15 == 47.3	4/24/25 20:45 == 48
4/24/25 7:20 == 47.3	4/24/25 11:50 == 48	4/24/25 16:20 == 47.9	4/24/25 20:50 == 48.1
4/24/25 7:25 == 40	4/24/25 11:55 == 47.7	4/24/25 16:25 == 40.2	4/24/25 20:55 == 48.1
4/24/25 7:30 == 34.6	4/24/25 12:00 == 47.6	4/24/25 16:30 == 34	4/24/25 21:00 == 48.1
4/24/25 7:35 == 34.4	4/24/25 12:05 == 48	4/24/25 16:35 == 33.5	4/24/25 21:05 == 47.9
4/24/25 7:40 == 34.7	4/24/25 12:10 == 47.6	4/24/25 16:40 == 33.5	4/24/25 21:10 == 47.5
4/24/25 7:45 == 34.5	4/24/25 12:15 == 47	4/24/25 16:45 == 33.5	4/24/25 21:15 == 47.8
4/24/25 7:50 == 34.6	4/24/25 12:20 == 47.8	4/24/25 16:50 == 33.5	4/24/25 21:20 == 48.1
4/24/25 7:55 == 34.2	4/24/25 12:25 == 47.8	4/24/25 16:55 == 33.5	4/24/25 21:25 == 47.7
4/24/25 8:00 == 34.4	4/24/25 12:30 == 47.2	4/24/25 17:00 == 33.7	4/24/25 21:30 == 47.8
4/24/25 8:05 == 34.3	4/24/25 12:35 == 48	4/24/25 17:05 == 33.7	4/24/25 21:35 == 48.1
4/24/25 8:10 == 33.9	4/24/25 12:40 == 47.8	4/24/25 17:10 == 37.8	4/24/25 21:40 == 48.1
4/24/25 8:15 == 33.9	4/24/25 12:45 == 48	4/24/25 17:15 == 48	4/24/25 21:45 == 47.7
4/24/25 8:20 == 34.1	4/24/25 12:50 == 47.9	4/24/25 17:20 == 48.1	4/24/25 21:50 == 47.7
4/24/25 8:25 == 40.9	4/24/25 12:55 == 47.9	4/24/25 17:25 == 48	4/24/25 21:55 == 48
4/24/25 8:30 == 46.6	4/24/25 13:00 == 47.6	4/24/25 17:30 == 47.9	4/24/25 22:00 == 47.8
4/24/25 8:35 == 48	4/24/25 13:05 == 48	4/24/25 17:35 == 48.1	4/24/25 22:05 == 47.3
4/24/25 8:40 == 47.7	4/24/25 13:10 == 48.1	4/24/25 17:40 == 48.2	4/24/25 22:10 == 42.4
4/24/25 8:45 == 47.7	4/24/25 13:15 == 47.9	4/24/25 17:45 == 47.8	4/24/25 22:15 == 33.8
4/24/25 8:50 == 47.9	4/24/25 13:20 == 48	4/24/25 17:50 == 48.1	4/24/25 22:20 == 33.6
4/24/25 8:55 == 47.9	4/24/25 13:25 == 39.4	4/24/25 17:55 == 48.1	4/24/25 22:25 == 33.6
4/24/25 9:00 == 47.9	4/24/25 13:30 == 34.3	4/24/25 18:00 == 48.1	4/24/25 22:30 == 33.5
4/24/25 9:05 == 47.9	4/24/25 13:35 == 33.4	4/24/25 18:05 == 48	4/24/25 22:35 == 33.6
4/24/25 9:10 == 47.9	4/24/25 13:40 == 33.5	4/24/25 18:10 == 47.3	4/24/25 22:40 == 33.7
4/24/25 9:15 == 48	4/24/25 13:45 == 33.5	4/24/25 18:15 == 47.5	4/24/25 22:45 == 33.3
4/24/25 9:20 == 48.1	4/24/25 13:50 == 33.6	4/24/25 18:20 == 48	4/24/25 22:50 == 33.7
4/24/25 9:25 == 48	4/24/25 13:55 == 33.6	4/24/25 18:25 == 47.6	4/24/25 22:55 == 36.6
4/24/25 9:30 == 48.1	4/24/25 14:00 == 33.6	4/24/25 18:30 == 47.9	4/24/25 23:00 == 47.6
4/24/25 9:35 == 48.1	4/24/25 14:05 == 33.7	4/24/25 18:35 == 48	4/24/25 23:05 == 48
4/24/25 9:40 == 47.8	4/24/25 14:10 == 39.4	4/24/25 18:40 == 48	4/24/25 23:10 == 47.9
4/24/25 9:45 == 47.2	4/24/25 14:15 == 46.9	4/24/25 18:45 == 48.1	4/24/25 23:15 == 48
4/24/25 9:50 == 48.1	4/24/25 14:20 == 48	4/24/25 18:50 == 48.1	4/24/25 23:20 == 48.1
4/24/25 9:55 == 48	4/24/25 14:25 == 47.8	4/24/25 18:55 == 48.1	4/24/25 23:25 == 48
4/24/25 10:00 == 47.9	4/24/25 14:30 == 47.3	4/24/25 19:00 == 48.1	4/24/25 23:30 == 48
4/24/25 10:05 == 47.9	4/24/25 14:35 == 47.9	4/24/25 19:05 == 48.1	4/24/25 23:35 == 48
4/24/25 10:10 == 39.4	4/24/25 14:40 == 47.8	4/24/25 19:10 == 41	4/24/25 23:40 == 48.2
4/24/25 10:15 == 33.6	4/24/25 14:45 == 47.4	4/24/25 19:15 == 33.6	4/24/25 23:45 == 48
4/24/25 10:20 == 33.3	4/24/25 14:50 == 47.9	4/24/25 19:20 == 33.2	4/24/25 23:50 == 48
4/24/25 10:25 == 33.6	4/24/25 14:55 == 48.1	4/24/25 19:25 == 33.4	4/24/25 23:55 == 48.1

Pumpback Station Discharge (0364)

4/25/25 0:00 == 48.1	4/25/25 4:30 == 33.4	4/25/25 9:00 == 33.3	4/25/25 13:30 == 47.4
4/25/25 0:05 == 48	4/25/25 4:35 == 33.5	4/25/25 9:05 == 33.4	4/25/25 13:35 == 47.9
4/25/25 0:10 == 47.9	4/25/25 4:40 == 37.2	4/25/25 9:10 == 33.3	4/25/25 13:40 == 48.1
4/25/25 0:15 == 47.5	4/25/25 4:45 == 45.5	4/25/25 9:15 == 33.5	4/25/25 13:45 == 48
4/25/25 0:20 == 47.6	4/25/25 4:50 == 47.9	4/25/25 9:20 == 33.5	4/25/25 13:50 == 47.8
4/25/25 0:25 == 47.9	4/25/25 4:55 == 47.9	4/25/25 9:25 == 34.9	4/25/25 13:55 == 47.7
4/25/25 0:30 == 48	4/25/25 5:00 == 47.7	4/25/25 9:30 == 47	4/25/25 14:00 == 47.8
4/25/25 0:35 == 48.1	4/25/25 5:05 == 47.7	4/25/25 9:35 == 47.8	4/25/25 14:05 == 47.8
4/25/25 0:40 == 48	4/25/25 5:10 == 47.9	4/25/25 9:40 == 47.6	4/25/25 14:10 == 45.2
4/25/25 0:45 == 48	4/25/25 5:15 == 47.6	4/25/25 9:45 == 47.7	4/25/25 14:15 == 34.4
4/25/25 0:50 == 48	4/25/25 5:20 == 47.8	4/25/25 9:50 == 47.9	4/25/25 14:20 == 34.3
4/25/25 0:55 == 48	4/25/25 5:25 == 48	4/25/25 9:55 == 48	4/25/25 14:25 == 34.4
4/25/25 1:00 == 47.9	4/25/25 5:30 == 47.7	4/25/25 10:00 == 48.1	4/25/25 14:30 == 34.1
4/25/25 1:05 == 46.9	4/25/25 5:35 == 47.7	4/25/25 10:05 == 48	4/25/25 14:35 == 34.3
4/25/25 1:10 == 42.6	4/25/25 5:40 == 47.5	4/25/25 10:10 == 48	4/25/25 14:40 == 34.7
4/25/25 1:15 == 33.4	4/25/25 5:45 == 47.2	4/25/25 10:15 == 48.1	4/25/25 14:45 == 34.6
4/25/25 1:20 == 33.6	4/25/25 5:50 == 47.6	4/25/25 10:20 == 48	4/25/25 14:50 == 34.6
4/25/25 1:25 == 33.4	4/25/25 5:55 == 47.7	4/25/25 10:25 == 47.6	4/25/25 14:55 == 36.9
4/25/25 1:30 == 33.4	4/25/25 6:00 == 47.5	4/25/25 10:30 == 47.7	4/25/25 15:00 == 46.1
4/25/25 1:35 == 33.4	4/25/25 6:05 == 47.8	4/25/25 10:35 == 48	4/25/25 15:05 == 48.1
4/25/25 1:40 == 34	4/25/25 6:10 == 48	4/25/25 10:40 == 47.6	4/25/25 15:10 == 47.8
4/25/25 1:45 == 33.6	4/25/25 6:15 == 48	4/25/25 10:45 == 47.3	4/25/25 15:15 == 47.7
4/25/25 1:50 == 33.6	4/25/25 6:20 == 48	4/25/25 10:50 == 47.7	4/25/25 15:20 == 48
4/25/25 1:55 == 37.4	4/25/25 6:25 == 47.9	4/25/25 10:55 == 47.9	4/25/25 15:25 == 48.1
4/25/25 2:00 == 46.1	4/25/25 6:30 == 47.9	4/25/25 11:00 == 48	4/25/25 15:30 == 48.1
4/25/25 2:05 == 47.9	4/25/25 6:35 == 47.8	4/25/25 11:05 == 48	4/25/25 15:35 == 48
4/25/25 2:10 == 48	4/25/25 6:40 == 43.9	4/25/25 11:10 == 47.9	4/25/25 15:40 == 48.1
4/25/25 2:15 == 48.1	4/25/25 6:45 == 33.4	4/25/25 11:15 == 47.6	4/25/25 15:45 == 48.1
4/25/25 2:20 == 48.1	4/25/25 6:50 == 33.8	4/25/25 11:20 == 47.7	4/25/25 15:50 == 47.9
4/25/25 2:25 == 48	4/25/25 6:55 == 34	4/25/25 11:25 == 44.7	4/25/25 15:55 == 48
4/25/25 2:30 == 47.9	4/25/25 7:00 == 33.9	4/25/25 11:30 == 34.8	4/25/25 16:00 == 48.1
4/25/25 2:35 == 48	4/25/25 7:05 == 33.7	4/25/25 11:35 == 34.7	4/25/25 16:05 == 48
4/25/25 2:40 == 48	4/25/25 7:10 == 34.2	4/25/25 11:40 == 34.8	4/25/25 16:10 == 47.7
4/25/25 2:45 == 48	4/25/25 7:15 == 34.1	4/25/25 11:45 == 35.1	4/25/25 16:15 == 47.5
4/25/25 2:50 == 48	4/25/25 7:20 == 33.9	4/25/25 11:50 == 35	4/25/25 16:20 == 47.9
4/25/25 2:55 == 47.6	4/25/25 7:25 == 38.2	4/25/25 11:55 == 35.2	4/25/25 16:25 == 48.1
4/25/25 3:00 == 47.3	4/25/25 7:30 == 45.4	4/25/25 12:00 == 34	4/25/25 16:30 == 47.9
4/25/25 3:05 == 47.7	4/25/25 7:35 == 47.8	4/25/25 12:05 == 34.2	4/25/25 16:35 == 48
4/25/25 3:10 == 48	4/25/25 7:40 == 47.8	4/25/25 12:10 == 36.2	4/25/25 16:40 == 46
4/25/25 3:15 == 47.9	4/25/25 7:45 == 47.9	4/25/25 12:15 == 46.3	4/25/25 16:45 == 34
4/25/25 3:20 == 48.1	4/25/25 7:50 == 48	4/25/25 12:20 == 47.9	4/25/25 16:50 == 33.8
4/25/25 3:25 == 48	4/25/25 7:55 == 48	4/25/25 12:25 == 48.3	4/25/25 16:55 == 33.8
4/25/25 3:30 == 48	4/25/25 8:00 == 48.1	4/25/25 12:30 == 48.1	4/25/25 17:00 == 34.3
4/25/25 3:35 == 48	4/25/25 8:05 == 48.1	4/25/25 12:35 == 47.6	4/25/25 17:05 == 34.1
4/25/25 3:40 == 47.8	4/25/25 8:10 == 47.8	4/25/25 12:40 == 47.7	4/25/25 17:10 == 34.4
4/25/25 3:45 == 47.1	4/25/25 8:15 == 47.5	4/25/25 12:45 == 48	4/25/25 17:15 == 34.8
4/25/25 3:50 == 47.5	4/25/25 8:20 == 47.7	4/25/25 12:50 == 48	4/25/25 17:20 == 34.8
4/25/25 3:55 == 43.6	4/25/25 8:25 == 47.7	4/25/25 12:55 == 48.1	4/25/25 17:25 == 35.9
4/25/25 4:00 == 33.3	4/25/25 8:30 == 47.4	4/25/25 13:00 == 48.1	4/25/25 17:30 == 46
4/25/25 4:05 == 33.3	4/25/25 8:35 == 47.7	4/25/25 13:05 == 47.9	4/25/25 17:35 == 47.9
4/25/25 4:10 == 33.4	4/25/25 8:40 == 44	4/25/25 13:10 == 47.7	4/25/25 17:40 == 48.1
4/25/25 4:15 == 33.2	4/25/25 8:45 == 33.4	4/25/25 13:15 == 47.9	4/25/25 17:45 == 48.1
4/25/25 4:20 == 33.5	4/25/25 8:50 == 33.4	4/25/25 13:20 == 48.1	4/25/25 17:50 == 48
4/25/25 4:25 == 33.7	4/25/25 8:55 == 33.3	4/25/25 13:25 == 47.8	4/25/25 17:55 == 48

Pumpback Station Discharge (0364)

4/25/25 18:00 == 47.9	4/25/25 22:30 == 34.4	4/26/25 3:00 == 48	4/26/25 7:30 == 48
4/25/25 18:05 == 47.9	4/25/25 22:35 == 34.3	4/26/25 3:05 == 47.9	4/26/25 7:35 == 48.1
4/25/25 18:10 == 47.7	4/25/25 22:40 == 34.5	4/26/25 3:10 == 48	4/26/25 7:40 == 47.9
4/25/25 18:15 == 47.7	4/25/25 22:45 == 34.1	4/26/25 3:15 == 47.9	4/26/25 7:45 == 47.9
4/25/25 18:20 == 47.9	4/25/25 22:50 == 34.2	4/26/25 3:20 == 47.9	4/26/25 7:50 == 48
4/25/25 18:25 == 47.7	4/25/25 22:55 == 36.2	4/26/25 3:25 == 46.6	4/26/25 7:55 == 45.6
4/25/25 18:30 == 47.5	4/25/25 23:00 == 44.5	4/26/25 3:30 == 34.3	4/26/25 8:00 == 37.2
4/25/25 18:35 == 47.8	4/25/25 23:05 == 47.9	4/26/25 3:35 == 34	4/26/25 8:05 == 34.2
4/25/25 18:40 == 47.9	4/25/25 23:10 == 48	4/26/25 3:40 == 34	4/26/25 8:10 == 34.3
4/25/25 18:45 == 48	4/25/25 23:15 == 48	4/26/25 3:45 == 33.8	4/26/25 8:15 == 34.2
4/25/25 18:50 == 48	4/25/25 23:20 == 47.9	4/26/25 3:50 == 33.7	4/26/25 8:20 == 33.9
4/25/25 18:55 == 48	4/25/25 23:25 == 48	4/26/25 3:55 == 33.8	4/26/25 8:25 == 34
4/25/25 19:00 == 47.9	4/25/25 23:30 == 48.1	4/26/25 4:00 == 33.9	4/26/25 8:30 == 33.9
4/25/25 19:05 == 48	4/25/25 23:35 == 48.1	4/26/25 4:05 == 33.9	4/26/25 8:35 == 33.7
4/25/25 19:10 == 47.8	4/25/25 23:40 == 48	4/26/25 4:10 == 35.3	4/26/25 8:40 == 33.9
4/25/25 19:15 == 47.8	4/25/25 23:45 == 47.9	4/26/25 4:15 == 43.9	4/26/25 8:45 == 34.2
4/25/25 19:20 == 47.9	4/25/25 23:50 == 48	4/26/25 4:20 == 47.9	4/26/25 8:50 == 34
4/25/25 19:25 == 45.9	4/25/25 23:55 == 48	4/26/25 4:25 == 48	4/26/25 8:55 == 34
4/25/25 19:30 == 33.8	4/26/25 0:00 == 48.1	4/26/25 4:30 == 48	4/26/25 9:00 == 44.4
4/25/25 19:35 == 33.7	4/26/25 0:05 == 48	4/26/25 4:35 == 48	4/26/25 9:05 == 47.6
4/25/25 19:40 == 33.8	4/26/25 0:10 == 48.1	4/26/25 4:40 == 47.9	4/26/25 9:10 == 48
4/25/25 19:45 == 34	4/26/25 0:15 == 47.9	4/26/25 4:45 == 47.9	4/26/25 9:15 == 47.9
4/25/25 19:50 == 34	4/26/25 0:20 == 48	4/26/25 4:50 == 48	4/26/25 9:20 == 48.1
4/25/25 19:55 == 33.9	4/26/25 0:25 == 48	4/26/25 4:55 == 48.1	4/26/25 9:25 == 48.1
4/25/25 20:00 == 34.1	4/26/25 0:30 == 47.4	4/26/25 5:00 == 48	4/26/25 9:30 == 47.9
4/25/25 20:05 == 34	4/26/25 0:35 == 48	4/26/25 5:05 == 48	4/26/25 9:35 == 47.6
4/25/25 20:10 == 35.9	4/26/25 0:40 == 48	4/26/25 5:10 == 48	4/26/25 9:40 == 47.4
4/25/25 20:15 == 45.1	4/26/25 0:45 == 48.1	4/26/25 5:15 == 48	4/26/25 9:45 == 47.6
4/25/25 20:20 == 47.9	4/26/25 0:50 == 48	4/26/25 5:20 == 48	4/26/25 9:50 == 47.9
4/25/25 20:25 == 47.8	4/26/25 0:55 == 46.6	4/26/25 5:25 == 47.9	4/26/25 9:55 == 48
4/25/25 20:30 == 47.6	4/26/25 1:00 == 34.6	4/26/25 5:30 == 47.5	4/26/25 10:00 == 48
4/25/25 20:35 == 47.9	4/26/25 1:05 == 34	4/26/25 5:35 == 48	4/26/25 10:05 == 48
4/25/25 20:40 == 48.2	4/26/25 1:10 == 34	4/26/25 5:40 == 48	4/26/25 10:10 == 48
4/25/25 20:45 == 48.1	4/26/25 1:15 == 34.1	4/26/25 5:45 == 47.6	4/26/25 10:15 == 48
4/25/25 20:50 == 47.9	4/26/25 1:20 == 34.3	4/26/25 5:50 == 48	4/26/25 10:20 == 48.1
4/25/25 20:55 == 47.9	4/26/25 1:25 == 34.3	4/26/25 5:55 == 48.2	4/26/25 10:25 == 48
4/25/25 21:00 == 48.1	4/26/25 1:30 == 34.3	4/26/25 6:00 == 47.1	4/26/25 10:30 == 48
4/25/25 21:05 == 48	4/26/25 1:35 == 34.3	4/26/25 6:05 == 48	4/26/25 10:35 == 48
4/25/25 21:10 == 47.8	4/26/25 1:40 == 36.3	4/26/25 6:10 == 46.9	4/26/25 10:40 == 47.9
4/25/25 21:15 == 47.7	4/26/25 1:45 == 44	4/26/25 6:15 == 35.5	4/26/25 10:45 == 47.3
4/25/25 21:20 == 48.1	4/26/25 1:50 == 47.9	4/26/25 6:20 == 34.2	4/26/25 10:50 == 47.9
4/25/25 21:25 == 47.8	4/26/25 1:55 == 47.8	4/26/25 6:25 == 34.4	4/26/25 10:55 == 47
4/25/25 21:30 == 47.4	4/26/25 2:00 == 47.7	4/26/25 6:30 == 34.6	4/26/25 11:00 == 36.3
4/25/25 21:35 == 47.9	4/26/25 2:05 == 47.9	4/26/25 6:35 == 34.6	4/26/25 11:05 == 34.8
4/25/25 21:40 == 47.8	4/26/25 2:10 == 48	4/26/25 6:40 == 34.6	4/26/25 11:10 == 34.9
4/25/25 21:45 == 47.5	4/26/25 2:15 == 48	4/26/25 6:45 == 34.4	4/26/25 11:15 == 35
4/25/25 21:50 == 48	4/26/25 2:20 == 47.9	4/26/25 6:50 == 34.4	4/26/25 11:20 == 35
4/25/25 21:55 == 48	4/26/25 2:25 == 47.7	4/26/25 6:55 == 36.3	4/26/25 11:25 == 34.9
4/25/25 22:00 == 48.2	4/26/25 2:30 == 47.7	4/26/25 7:00 == 43.6	4/26/25 11:30 == 34.9
4/25/25 22:05 == 48	4/26/25 2:35 == 47.9	4/26/25 7:05 == 47.9	4/26/25 11:35 == 34.9
4/25/25 22:10 == 46	4/26/25 2:40 == 47.9	4/26/25 7:10 == 47.8	4/26/25 11:40 == 35.2
4/25/25 22:15 == 34.6	4/26/25 2:45 == 47.8	4/26/25 7:15 == 47.8	4/26/25 11:45 == 44.9
4/25/25 22:20 == 34.4	4/26/25 2:50 == 48	4/26/25 7:20 == 48	4/26/25 11:50 == 48
4/25/25 22:25 == 34.5	4/26/25 2:55 == 48.1	4/26/25 7:25 == 48	4/26/25 11:55 == 48

Pumpback Station Discharge (0364)

4/26/25 12:00 == 48	4/26/25 16:30 == 34.5	4/26/25 21:00 == 48	4/27/25 1:30 == 48
4/26/25 12:05 == 48	4/26/25 16:35 == 34.5	4/26/25 21:05 == 47.9	4/27/25 1:35 == 48.2
4/26/25 12:10 == 47.8	4/26/25 16:40 == 34.3	4/26/25 21:10 == 48	4/27/25 1:40 == 47.9
4/26/25 12:15 == 47.9	4/26/25 16:45 == 43.5	4/26/25 21:15 == 47.4	4/27/25 1:45 == 47.6
4/26/25 12:20 == 47.9	4/26/25 16:50 == 47.4	4/26/25 21:20 == 48.1	4/27/25 1:50 == 48
4/26/25 12:25 == 47.9	4/26/25 16:55 == 48	4/26/25 21:25 == 47.9	4/27/25 1:55 == 47.8
4/26/25 12:30 == 48	4/26/25 17:00 == 48	4/26/25 21:30 == 37.4	4/27/25 2:00 == 47.5
4/26/25 12:35 == 48	4/26/25 17:05 == 48	4/26/25 21:35 == 34.4	4/27/25 2:05 == 48.2
4/26/25 12:40 == 48	4/26/25 17:10 == 47.8	4/26/25 21:40 == 34.5	4/27/25 2:10 == 48
4/26/25 12:45 == 47.9	4/26/25 17:15 == 47.8	4/26/25 21:45 == 34.4	4/27/25 2:15 == 47.5
4/26/25 12:50 == 47.8	4/26/25 17:20 == 47.9	4/26/25 21:50 == 34.4	4/27/25 2:20 == 47.8
4/26/25 12:55 == 48	4/26/25 17:25 == 48	4/26/25 21:55 == 34.3	4/27/25 2:25 == 48
4/26/25 13:00 == 48.1	4/26/25 17:30 == 48.1	4/26/25 22:00 == 34.3	4/27/25 2:30 == 48
4/26/25 13:05 == 48.1	4/26/25 17:35 == 48.1	4/26/25 22:05 == 34.4	4/27/25 2:35 == 47.9
4/26/25 13:10 == 48.1	4/26/25 17:40 == 48.1	4/26/25 22:10 == 34.4	4/27/25 2:40 == 48.2
4/26/25 13:15 == 48.2	4/26/25 17:45 == 48.1	4/26/25 22:15 == 42.9	4/27/25 2:45 == 37.8
4/26/25 13:20 == 48	4/26/25 17:50 == 48.1	4/26/25 22:20 == 47.6	4/27/25 2:50 == 34.5
4/26/25 13:25 == 46.8	4/26/25 17:55 == 48	4/26/25 22:25 == 48.1	4/27/25 2:55 == 34.4
4/26/25 13:30 == 36.9	4/26/25 18:00 == 48	4/26/25 22:30 == 48.1	4/27/25 3:00 == 34.2
4/26/25 13:35 == 34.3	4/26/25 18:05 == 48	4/26/25 22:35 == 48.1	4/27/25 3:05 == 34.2
4/26/25 13:40 == 34	4/26/25 18:10 == 47.8	4/26/25 22:40 == 47.8	4/27/25 3:10 == 34.3
4/26/25 13:45 == 34.1	4/26/25 18:15 == 47.4	4/26/25 22:45 == 47.7	4/27/25 3:15 == 34.2
4/26/25 13:50 == 34.1	4/26/25 18:20 == 48	4/26/25 22:50 == 48	4/27/25 3:20 == 34
4/26/25 13:55 == 34.1	4/26/25 18:25 == 48	4/26/25 22:55 == 48	4/27/25 3:25 == 34
4/26/25 14:00 == 34.3	4/26/25 18:30 == 48.1	4/26/25 23:00 == 48.1	4/27/25 3:30 == 41.6
4/26/25 14:05 == 34.2	4/26/25 18:35 == 48.1	4/26/25 23:05 == 48.1	4/27/25 3:35 == 47.1
4/26/25 14:10 == 34.3	4/26/25 18:40 == 47.1	4/26/25 23:10 == 48.1	4/27/25 3:40 == 48
4/26/25 14:15 == 44	4/26/25 18:45 == 36.7	4/26/25 23:15 == 47.9	4/27/25 3:45 == 48
4/26/25 14:20 == 47.6	4/26/25 18:50 == 34	4/26/25 23:20 == 47.8	4/27/25 3:50 == 48
4/26/25 14:25 == 47.7	4/26/25 18:55 == 33.9	4/26/25 23:25 == 48.1	4/27/25 3:55 == 48
4/26/25 14:30 == 47.4	4/26/25 19:00 == 33.9	4/26/25 23:30 == 48	4/27/25 4:00 == 47.9
4/26/25 14:35 == 47.7	4/26/25 19:05 == 34	4/26/25 23:35 == 48.1	4/27/25 4:05 == 48
4/26/25 14:40 == 47.6	4/26/25 19:10 == 34	4/26/25 23:40 == 48	4/27/25 4:10 == 48.1
4/26/25 14:45 == 47.6	4/26/25 19:15 == 33.9	4/26/25 23:45 == 47.9	4/27/25 4:15 == 48.1
4/26/25 14:50 == 47.9	4/26/25 19:20 == 33.9	4/26/25 23:50 == 48	4/27/25 4:20 == 48
4/26/25 14:55 == 48	4/26/25 19:25 == 33.9	4/26/25 23:55 == 47.9	4/27/25 4:25 == 47.9
4/26/25 15:00 == 47.9	4/26/25 19:30 == 42.7	4/27/25 0:00 == 47.9	4/27/25 4:30 == 48
4/26/25 15:05 == 47.9	4/26/25 19:35 == 47.3	4/27/25 0:05 == 48	4/27/25 4:35 == 48
4/26/25 15:10 == 48	4/26/25 19:40 == 47.6	4/27/25 0:10 == 47.9	4/27/25 4:40 == 48
4/26/25 15:15 == 48	4/26/25 19:45 == 47.7	4/27/25 0:15 == 37.2	4/27/25 4:45 == 47.9
4/26/25 15:20 == 47.9	4/26/25 19:50 == 47.9	4/27/25 0:20 == 34	4/27/25 4:50 == 48
4/26/25 15:25 == 47.9	4/26/25 19:55 == 47.9	4/27/25 0:25 == 33.8	4/27/25 4:55 == 48.1
4/26/25 15:30 == 47.6	4/26/25 20:00 == 48	4/27/25 0:30 == 33.8	4/27/25 5:00 == 48
4/26/25 15:35 == 48	4/26/25 20:05 == 48	4/27/25 0:35 == 33.8	4/27/25 5:05 == 48.1
4/26/25 15:40 == 48	4/26/25 20:10 == 48	4/27/25 0:40 == 33.8	4/27/25 5:10 == 48.1
4/26/25 15:45 == 48	4/26/25 20:15 == 47.6	4/27/25 0:45 == 33.8	4/27/25 5:15 == 48.1
4/26/25 15:50 == 47.9	4/26/25 20:20 == 47.5	4/27/25 0:50 == 33.9	4/27/25 5:20 == 48
4/26/25 15:55 == 46.7	4/26/25 20:25 == 47.5	4/27/25 0:55 == 33.8	4/27/25 5:25 == 47.9
4/26/25 16:00 == 38	4/26/25 20:30 == 47.4	4/27/25 1:00 == 41.7	4/27/25 5:30 == 38.1
4/26/25 16:05 == 34.9	4/26/25 20:35 == 48	4/27/25 1:05 == 47	4/27/25 5:35 == 34.1
4/26/25 16:10 == 34.9	4/26/25 20:40 == 48	4/27/25 1:10 == 47.7	4/27/25 5:40 == 34.1
4/26/25 16:15 == 34.7	4/26/25 20:45 == 47.9	4/27/25 1:15 == 48	4/27/25 5:45 == 33.9
4/26/25 16:20 == 34.6	4/26/25 20:50 == 48.1	4/27/25 1:20 == 48.1	4/27/25 5:50 == 33.9
4/26/25 16:25 == 34.7	4/26/25 20:55 == 48.1	4/27/25 1:25 == 47.9	4/27/25 5:55 == 34

Pumpback Station Discharge (0364)

4/27/25 6:00 == 33.9	4/27/25 10:30 == 34.4	4/27/25 15:00 == 47.6	4/27/25 19:30 == 48
4/27/25 6:05 == 33.8	4/27/25 10:35 == 34.4	4/27/25 15:05 == 48	4/27/25 19:35 == 48
4/27/25 6:10 == 33.9	4/27/25 10:40 == 34.5	4/27/25 15:10 == 48.1	4/27/25 19:40 == 47.7
4/27/25 6:15 == 41	4/27/25 10:45 == 41.2	4/27/25 15:15 == 48	4/27/25 19:45 == 47.4
4/27/25 6:20 == 47	4/27/25 10:50 == 46.6	4/27/25 15:20 == 47.8	4/27/25 19:50 == 48
4/27/25 6:25 == 47.8	4/27/25 10:55 == 48	4/27/25 15:25 == 48	4/27/25 19:55 == 47.9
4/27/25 6:30 == 47.8	4/27/25 11:00 == 48.1	4/27/25 15:30 == 47.4	4/27/25 20:00 == 47.9
4/27/25 6:35 == 48	4/27/25 11:05 == 48	4/27/25 15:35 == 48.1	4/27/25 20:05 == 48.2
4/27/25 6:40 == 48	4/27/25 11:10 == 47.7	4/27/25 15:40 == 48	4/27/25 20:10 == 48
4/27/25 6:45 == 48	4/27/25 11:15 == 47.6	4/27/25 15:45 == 39.7	4/27/25 20:15 == 48
4/27/25 6:50 == 47.9	4/27/25 11:20 == 47.9	4/27/25 15:50 == 34.7	4/27/25 20:20 == 47.9
4/27/25 6:55 == 47.8	4/27/25 11:25 == 48	4/27/25 15:55 == 34.2	4/27/25 20:25 == 48
4/27/25 7:00 == 47.7	4/27/25 11:30 == 47.9	4/27/25 16:00 == 34	4/27/25 20:30 == 47.2
4/27/25 7:05 == 48	4/27/25 11:35 == 47.9	4/27/25 16:05 == 34.1	4/27/25 20:35 == 48
4/27/25 7:10 == 48.1	4/27/25 11:40 == 47.7	4/27/25 16:10 == 34.2	4/27/25 20:40 == 48.1
4/27/25 7:15 == 48	4/27/25 11:45 == 47.6	4/27/25 16:15 == 34	4/27/25 20:45 == 47.8
4/27/25 7:20 == 48	4/27/25 11:50 == 48	4/27/25 16:20 == 33.9	4/27/25 20:50 == 48
4/27/25 7:25 == 47.8	4/27/25 11:55 == 48	4/27/25 16:25 == 33.8	4/27/25 20:55 == 48.2
4/27/25 7:30 == 47.8	4/27/25 12:00 == 47.8	4/27/25 16:30 == 40.1	4/27/25 21:00 == 48
4/27/25 7:35 == 48.1	4/27/25 12:05 == 48	4/27/25 16:35 == 46.1	4/27/25 21:05 == 48
4/27/25 7:40 == 48	4/27/25 12:10 == 47.9	4/27/25 16:40 == 47.7	4/27/25 21:10 == 47.5
4/27/25 7:45 == 48.1	4/27/25 12:15 == 47.9	4/27/25 16:45 == 47.9	4/27/25 21:15 == 40.2
4/27/25 7:50 == 48.1	4/27/25 12:20 == 47.9	4/27/25 16:50 == 48.1	4/27/25 21:20 == 34.8
4/27/25 7:55 == 48.1	4/27/25 12:25 == 47.9	4/27/25 16:55 == 48.1	4/27/25 21:25 == 33.8
4/27/25 8:00 == 38.7	4/27/25 12:30 == 47.5	4/27/25 17:00 == 48	4/27/25 21:30 == 33.6
4/27/25 8:05 == 35	4/27/25 12:35 == 48	4/27/25 17:05 == 47.9	4/27/25 21:35 == 33.6
4/27/25 8:10 == 34.7	4/27/25 12:40 == 48	4/27/25 17:10 == 47.7	4/27/25 21:40 == 33.7
4/27/25 8:15 == 34.5	4/27/25 12:45 == 48	4/27/25 17:15 == 47.4	4/27/25 21:45 == 38.9
4/27/25 8:20 == 34.6	4/27/25 12:50 == 48	4/27/25 17:20 == 48.1	4/27/25 21:50 == 45.6
4/27/25 8:25 == 34.7	4/27/25 12:55 == 48	4/27/25 17:25 == 48.1	4/27/25 21:55 == 48
4/27/25 8:30 == 34.3	4/27/25 13:00 == 48.1	4/27/25 17:30 == 48.1	4/27/25 22:00 == 48
4/27/25 8:35 == 34	4/27/25 13:05 == 48.2	4/27/25 17:35 == 48	4/27/25 22:05 == 48
4/27/25 8:40 == 34.1	4/27/25 13:10 == 48.1	4/27/25 17:40 == 48.1	4/27/25 22:10 == 48.1
4/27/25 8:45 == 41.2	4/27/25 13:15 == 39.2	4/27/25 17:45 == 48	4/27/25 22:15 == 47.8
4/27/25 8:50 == 46.9	4/27/25 13:20 == 34.2	4/27/25 17:50 == 48	4/27/25 22:20 == 47.7
4/27/25 8:55 == 48	4/27/25 13:25 == 33.8	4/27/25 17:55 == 48.3	4/27/25 22:25 == 48
4/27/25 9:00 == 48	4/27/25 13:30 == 33.6	4/27/25 18:00 == 48.1	4/27/25 22:30 == 48
4/27/25 9:05 == 47.9	4/27/25 13:35 == 33.6	4/27/25 18:05 == 47.9	4/27/25 22:35 == 48
4/27/25 9:10 == 47.9	4/27/25 13:40 == 33.6	4/27/25 18:10 == 48	4/27/25 22:40 == 47.7
4/27/25 9:15 == 47.9	4/27/25 13:45 == 39.9	4/27/25 18:15 == 39.4	4/27/25 22:45 == 47.4
4/27/25 9:20 == 47.8	4/27/25 13:50 == 46	4/27/25 18:20 == 34	4/27/25 22:50 == 48
4/27/25 9:25 == 48	4/27/25 13:55 == 47.8	4/27/25 18:25 == 33.7	4/27/25 22:55 == 47.8
4/27/25 9:30 == 48.1	4/27/25 14:00 == 47.8	4/27/25 18:30 == 33.5	4/27/25 23:00 == 48.1
4/27/25 9:35 == 48.1	4/27/25 14:05 == 47.9	4/27/25 18:35 == 33.6	4/27/25 23:05 == 47.9
4/27/25 9:40 == 48	4/27/25 14:10 == 48	4/27/25 18:40 == 33.7	4/27/25 23:10 == 48.1
4/27/25 9:45 == 48.2	4/27/25 14:15 == 48	4/27/25 18:45 == 33.8	4/27/25 23:15 == 48
4/27/25 9:50 == 48.1	4/27/25 14:20 == 47.9	4/27/25 18:50 == 33.8	4/27/25 23:20 == 48
4/27/25 9:55 == 46.9	4/27/25 14:25 == 47.6	4/27/25 18:55 == 33.7	4/27/25 23:25 == 48.1
4/27/25 10:00 == 40.5	4/27/25 14:30 == 47.5	4/27/25 19:00 == 39.8	4/27/25 23:30 == 40.7
4/27/25 10:05 == 34	4/27/25 14:35 == 48	4/27/25 19:05 == 46	4/27/25 23:35 == 34.4
4/27/25 10:10 == 34.2	4/27/25 14:40 == 47.9	4/27/25 19:10 == 47.9	4/27/25 23:40 == 33.5
4/27/25 10:15 == 34.2	4/27/25 14:45 == 47.3	4/27/25 19:15 == 48	4/27/25 23:45 == 33.5
4/27/25 10:20 == 34.3	4/27/25 14:50 == 47.5	4/27/25 19:20 == 47.9	4/27/25 23:50 == 33.5
4/27/25 10:25 == 34.2	4/27/25 14:55 == 47.9	4/27/25 19:25 == 47.9	4/27/25 23:55 == 33.6

Pumpback Station Discharge (0364)

4/28/25 0:00 == 33.5	4/28/25 4:30 == 47.9	4/28/25 9:00 == 48	4/28/25 13:30 == 47.6
4/28/25 0:05 == 33.5	4/28/25 4:35 == 48	4/28/25 9:05 == 48	4/28/25 13:35 == 48
4/28/25 0:10 == 33.5	4/28/25 4:40 == 48.1	4/28/25 9:10 == 47.9	4/28/25 13:40 == 48
4/28/25 0:15 == 39	4/28/25 4:45 == 41.5	4/28/25 9:15 == 47.9	4/28/25 13:45 == 43.6
4/28/25 0:20 == 45.2	4/28/25 4:50 == 34.7	4/28/25 9:20 == 48.1	4/28/25 13:50 == 35.1
4/28/25 0:25 == 47.2	4/28/25 4:55 == 33.4	4/28/25 9:25 == 48.1	4/28/25 13:55 == 33.9
4/28/25 0:30 == 47.7	4/28/25 5:00 == 33.4	4/28/25 9:30 == 47.9	4/28/25 14:00 == 33.9
4/28/25 0:35 == 47.9	4/28/25 5:05 == 33.4	4/28/25 9:35 == 47.5	4/28/25 14:05 == 33.9
4/28/25 0:40 == 47.9	4/28/25 5:10 == 33.6	4/28/25 9:40 == 47.9	4/28/25 14:10 == 33.9
4/28/25 0:45 == 48	4/28/25 5:15 == 33.6	4/28/25 9:45 == 47.3	4/28/25 14:15 == 33.7
4/28/25 0:50 == 48	4/28/25 5:20 == 33.5	4/28/25 9:50 == 47.8	4/28/25 14:20 == 33.7
4/28/25 0:55 == 47.9	4/28/25 5:25 == 33.6	4/28/25 9:55 == 47.6	4/28/25 14:25 == 33.7
4/28/25 1:00 == 48	4/28/25 5:30 == 38.4	4/28/25 10:00 == 47.8	4/28/25 14:30 == 34.4
4/28/25 1:05 == 48	4/28/25 5:35 == 45	4/28/25 10:05 == 48	4/28/25 14:35 == 47.4
4/28/25 1:10 == 48.1	4/28/25 5:40 == 47.5	4/28/25 10:10 == 47.5	4/28/25 14:40 == 48.1
4/28/25 1:15 == 48.1	4/28/25 5:45 == 47.7	4/28/25 10:15 == 47.6	4/28/25 14:45 == 47.5
4/28/25 1:20 == 48	4/28/25 5:50 == 48	4/28/25 10:20 == 47.9	4/28/25 14:50 == 47.5
4/28/25 1:25 == 47.9	4/28/25 5:55 == 48	4/28/25 10:25 == 47.9	4/28/25 14:55 == 47.9
4/28/25 1:30 == 47.9	4/28/25 6:00 == 48.1	4/28/25 10:30 == 41.9	4/28/25 15:00 == 47.9
4/28/25 1:35 == 48	4/28/25 6:05 == 48	4/28/25 10:35 == 35.5	4/28/25 15:05 == 47.8
4/28/25 1:40 == 48.1	4/28/25 6:10 == 48	4/28/25 10:40 == 34	4/28/25 15:10 == 47.7
4/28/25 1:45 == 47.2	4/28/25 6:15 == 48	4/28/25 10:45 == 34.2	4/28/25 15:15 == 47.6
4/28/25 1:50 == 48.1	4/28/25 6:20 == 48.1	4/28/25 10:50 == 34	4/28/25 15:20 == 47.8
4/28/25 1:55 == 48.3	4/28/25 6:25 == 48	4/28/25 10:55 == 34	4/28/25 15:25 == 48.1
4/28/25 2:00 == 47.3	4/28/25 6:30 == 47.6	4/28/25 11:00 == 34.2	4/28/25 15:30 == 48.1
4/28/25 2:05 == 47.9	4/28/25 6:35 == 48	4/28/25 11:05 == 34.2	4/28/25 15:35 == 48
4/28/25 2:10 == 48	4/28/25 6:40 == 48	4/28/25 11:10 == 34.2	4/28/25 15:40 == 47.9
4/28/25 2:15 == 41	4/28/25 6:45 == 47.9	4/28/25 11:15 == 37.8	4/28/25 15:45 == 47.9
4/28/25 2:20 == 35.1	4/28/25 6:50 == 47.9	4/28/25 11:20 == 45.7	4/28/25 15:50 == 48
4/28/25 2:25 == 34	4/28/25 6:55 == 48.1	4/28/25 11:25 == 47.9	4/28/25 15:55 == 48.1
4/28/25 2:30 == 34.1	4/28/25 7:00 == 47.2	4/28/25 11:30 == 48.1	4/28/25 16:00 == 48.1
4/28/25 2:35 == 34	4/28/25 7:05 == 47.8	4/28/25 11:35 == 48	4/28/25 16:05 == 48
4/28/25 2:40 == 33.9	4/28/25 7:10 == 48.3	4/28/25 11:40 == 48.1	4/28/25 16:10 == 47.9
4/28/25 2:45 == 33.9	4/28/25 7:15 == 41.5	4/28/25 11:45 == 48	4/28/25 16:15 == 43.6
4/28/25 2:50 == 33.8	4/28/25 7:20 == 34.9	4/28/25 11:50 == 48.1	4/28/25 16:20 == 35.8
4/28/25 2:55 == 33.8	4/28/25 7:25 == 34.1	4/28/25 11:55 == 48.1	4/28/25 16:25 == 34.3
4/28/25 3:00 == 38.9	4/28/25 7:30 == 34	4/28/25 12:00 == 47.5	4/28/25 16:30 == 34.2
4/28/25 3:05 == 45.6	4/28/25 7:35 == 34.1	4/28/25 12:05 == 47.8	4/28/25 16:35 == 34.2
4/28/25 3:10 == 48	4/28/25 7:40 == 34.2	4/28/25 12:10 == 48	4/28/25 16:40 == 34.3
4/28/25 3:15 == 48.1	4/28/25 7:45 == 34.1	4/28/25 12:15 == 47	4/28/25 16:45 == 34.3
4/28/25 3:20 == 48	4/28/25 7:50 == 34.1	4/28/25 12:20 == 47.9	4/28/25 16:50 == 34.2
4/28/25 3:25 == 48.1	4/28/25 7:55 == 34	4/28/25 12:25 == 48.2	4/28/25 16:55 == 34.2
4/28/25 3:30 == 48	4/28/25 8:00 == 34	4/28/25 12:30 == 47.4	4/28/25 17:00 == 35.3
4/28/25 3:35 == 48.1	4/28/25 8:05 == 34.1	4/28/25 12:35 == 47.9	4/28/25 17:05 == 46.5
4/28/25 3:40 == 47.8	4/28/25 8:10 == 34	4/28/25 12:40 == 48.1	4/28/25 17:10 == 48
4/28/25 3:45 == 47.3	4/28/25 8:15 == 38.2	4/28/25 12:45 == 48	4/28/25 17:15 == 47.1
4/28/25 3:50 == 47.9	4/28/25 8:20 == 45	4/28/25 12:50 == 48.2	4/28/25 17:20 == 48.1
4/28/25 3:55 == 48	4/28/25 8:25 == 47.8	4/28/25 12:55 == 48.1	4/28/25 17:25 == 47.9
4/28/25 4:00 == 47.9	4/28/25 8:30 == 47.9	4/28/25 13:00 == 48	4/28/25 17:30 == 47.9
4/28/25 4:05 == 47.9	4/28/25 8:35 == 48	4/28/25 13:05 == 48	4/28/25 17:35 == 48
4/28/25 4:10 == 47.9	4/28/25 8:40 == 48	4/28/25 13:10 == 47.9	4/28/25 17:40 == 48.1
4/28/25 4:15 == 47.6	4/28/25 8:45 == 48	4/28/25 13:15 == 48	4/28/25 17:45 == 47.8
4/28/25 4:20 == 48.1	4/28/25 8:50 == 48	4/28/25 13:20 == 48.1	4/28/25 17:50 == 47.9
4/28/25 4:25 == 48.1	4/28/25 8:55 == 47.9	4/28/25 13:25 == 47.7	4/28/25 17:55 == 48

Pumpback Station Discharge (0364)

4/28/25 18:00 == 48	4/28/25 22:30 == 34.1	4/29/25 3:00 == 45.3	4/29/25 7:30 == 48
4/28/25 18:05 == 48	4/28/25 22:35 == 46.7	4/29/25 3:05 == 35.2	4/29/25 7:35 == 48
4/28/25 18:10 == 47.7	4/28/25 22:40 == 48.1	4/29/25 3:10 == 33.9	4/29/25 7:40 == 47.7
4/28/25 18:15 == 47.6	4/28/25 22:45 == 47.5	4/29/25 3:15 == 33.8	4/29/25 7:45 == 44.3
4/28/25 18:20 == 47.9	4/28/25 22:50 == 48	4/29/25 3:20 == 33.7	4/29/25 7:50 == 37.7
4/28/25 18:25 == 47.9	4/28/25 22:55 == 48.1	4/29/25 3:25 == 34	4/29/25 7:55 == 34.8
4/28/25 18:30 == 47.7	4/28/25 23:00 == 48	4/29/25 3:30 == 33.8	4/29/25 8:00 == 35.1
4/28/25 18:35 == 47.8	4/28/25 23:05 == 48	4/29/25 3:35 == 33.7	4/29/25 8:05 == 34.9
4/28/25 18:40 == 47.8	4/28/25 23:10 == 47.9	4/29/25 3:40 == 34	4/29/25 8:10 == 34.7
4/28/25 18:45 == 47.7	4/28/25 23:15 == 47.8	4/29/25 3:45 == 33.7	4/29/25 8:15 == 34.6
4/28/25 18:50 == 48	4/28/25 23:20 == 48	4/29/25 3:50 == 44.9	4/29/25 8:20 == 34.4
4/28/25 18:55 == 48	4/28/25 23:25 == 48.1	4/29/25 3:55 == 47.8	4/29/25 8:25 == 34.3
4/28/25 19:00 == 44.2	4/28/25 23:30 == 48	4/29/25 4:00 == 48.1	4/29/25 8:30 == 34
4/28/25 19:05 == 35.2	4/28/25 23:35 == 48.1	4/29/25 4:05 == 47.9	4/29/25 8:35 == 34
4/28/25 19:10 == 33.9	4/28/25 23:40 == 48	4/29/25 4:10 == 48	4/29/25 8:40 == 34
4/28/25 19:15 == 33.8	4/28/25 23:45 == 47.9	4/29/25 4:15 == 47.9	4/29/25 8:45 == 37
4/28/25 19:20 == 33.7	4/28/25 23:50 == 48	4/29/25 4:20 == 47.9	4/29/25 8:50 == 45.6
4/28/25 19:25 == 33.7	4/28/25 23:55 == 47.9	4/29/25 4:25 == 48	4/29/25 8:55 == 47.8
4/28/25 19:30 == 33.5	4/29/25 0:00 == 47.9	4/29/25 4:30 == 48	4/29/25 9:00 == 47.9
4/28/25 19:35 == 33.6	4/29/25 0:05 == 48	4/29/25 4:35 == 48.1	4/29/25 9:05 == 48
4/28/25 19:40 == 33.7	4/29/25 0:10 == 47.9	4/29/25 4:40 == 48.1	4/29/25 9:10 == 47.9
4/28/25 19:45 == 34.1	4/29/25 0:15 == 47.7	4/29/25 4:45 == 48.1	4/29/25 9:15 == 48
4/28/25 19:50 == 47.2	4/29/25 0:20 == 47.6	4/29/25 4:50 == 48	4/29/25 9:20 == 48.1
4/28/25 19:55 == 48.1	4/29/25 0:25 == 47.8	4/29/25 4:55 == 48	4/29/25 9:25 == 48
4/28/25 20:00 == 47.5	4/29/25 0:30 == 45.1	4/29/25 5:00 == 48.1	4/29/25 9:30 == 48
4/28/25 20:05 == 47.8	4/29/25 0:35 == 34.9	4/29/25 5:05 == 48	4/29/25 9:35 == 48.2
4/28/25 20:10 == 47.9	4/29/25 0:40 == 33.7	4/29/25 5:10 == 48.1	4/29/25 9:40 == 48.1
4/28/25 20:15 == 47.3	4/29/25 0:45 == 33.7	4/29/25 5:15 == 48	4/29/25 9:45 == 48.1
4/28/25 20:20 == 47.8	4/29/25 0:50 == 33.8	4/29/25 5:20 == 48	4/29/25 9:50 == 48
4/28/25 20:25 == 48	4/29/25 0:55 == 33.7	4/29/25 5:25 == 47.9	4/29/25 9:55 == 48
4/28/25 20:30 == 48.1	4/29/25 1:00 == 33.8	4/29/25 5:30 == 45.3	4/29/25 10:00 == 48
4/28/25 20:35 == 48.1	4/29/25 1:05 == 33.7	4/29/25 5:35 == 36.3	4/29/25 10:05 == 47.9
4/28/25 20:40 == 48	4/29/25 1:10 == 34	4/29/25 5:40 == 33.9	4/29/25 10:10 == 48
4/28/25 20:45 == 48	4/29/25 1:15 == 34.2	4/29/25 5:45 == 34.1	4/29/25 10:15 == 48.2
4/28/25 20:50 == 47.8	4/29/25 1:20 == 45.7	4/29/25 5:50 == 34	4/29/25 10:20 == 48.1
4/28/25 20:55 == 47.9	4/29/25 1:25 == 47.8	4/29/25 5:55 == 34.1	4/29/25 10:25 == 47.9
4/28/25 21:00 == 48	4/29/25 1:30 == 48.1	4/29/25 6:00 == 34.1	4/29/25 10:30 == 48
4/28/25 21:05 == 48	4/29/25 1:35 == 48.1	4/29/25 6:05 == 33.9	4/29/25 10:35 == 48.1
4/28/25 21:10 == 47.6	4/29/25 1:40 == 47.7	4/29/25 6:10 == 33.8	4/29/25 10:40 == 47.7
4/28/25 21:15 == 47.5	4/29/25 1:45 == 47.8	4/29/25 6:15 == 34.1	4/29/25 10:45 == 47.6
4/28/25 21:20 == 47.9	4/29/25 1:50 == 47.9	4/29/25 6:20 == 45.4	4/29/25 10:50 == 48.1
4/28/25 21:25 == 47.9	4/29/25 1:55 == 47.8	4/29/25 6:25 == 48	4/29/25 10:55 == 48.1
4/28/25 21:30 == 47.9	4/29/25 2:00 == 47.7	4/29/25 6:30 == 47.5	4/29/25 11:00 == 43.5
4/28/25 21:35 == 48	4/29/25 2:05 == 47.8	4/29/25 6:35 == 48	4/29/25 11:05 == 36
4/28/25 21:40 == 47.9	4/29/25 2:10 == 47.9	4/29/25 6:40 == 48.1	4/29/25 11:10 == 35.2
4/28/25 21:45 == 44.6	4/29/25 2:15 == 47.9	4/29/25 6:45 == 47.7	4/29/25 11:15 == 35.1
4/28/25 21:50 == 35.4	4/29/25 2:20 == 47.9	4/29/25 6:50 == 47.8	4/29/25 11:20 == 35.1
4/28/25 21:55 == 34	4/29/25 2:25 == 48	4/29/25 6:55 == 48	4/29/25 11:25 == 35.3
4/28/25 22:00 == 34.1	4/29/25 2:30 == 48	4/29/25 7:00 == 47.9	4/29/25 11:30 == 35.2
4/28/25 22:05 == 34.1	4/29/25 2:35 == 48	4/29/25 7:05 == 48	4/29/25 11:35 == 35.1
4/28/25 22:10 == 34.1	4/29/25 2:40 == 48	4/29/25 7:10 == 47.8	4/29/25 11:40 == 35.5
4/28/25 22:15 == 34.2	4/29/25 2:45 == 48	4/29/25 7:15 == 47.7	4/29/25 11:45 == 35.3
4/28/25 22:20 == 34.1	4/29/25 2:50 == 48	4/29/25 7:20 == 47.9	4/29/25 11:50 == 35.2
4/28/25 22:25 == 34.1	4/29/25 2:55 == 48.1	4/29/25 7:25 == 48	4/29/25 11:55 == 34.9

Pumpback Station Discharge (0364)

4/29/25 12:00 == 35.7	4/29/25 16:30 == 47.9	4/29/25 21:00 == 47.9	4/30/25 1:30 == 44.9
4/29/25 12:05 == 47.4	4/29/25 16:35 == 48.1	4/29/25 21:05 == 47.8	4/30/25 1:35 == 36.7
4/29/25 12:10 == 47.2	4/29/25 16:40 == 48	4/29/25 21:10 == 47.6	4/30/25 1:40 == 34.4
4/29/25 12:15 == 47.9	4/29/25 16:45 == 48.1	4/29/25 21:15 == 47.8	4/30/25 1:45 == 34.5
4/29/25 12:20 == 48	4/29/25 16:50 == 48.1	4/29/25 21:20 == 48	4/30/25 1:50 == 34.5
4/29/25 12:25 == 47.5	4/29/25 16:55 == 47.9	4/29/25 21:25 == 48	4/30/25 1:55 == 34.6
4/29/25 12:30 == 47.8	4/29/25 17:00 == 45.6	4/29/25 21:30 == 48	4/30/25 2:00 == 34.6
4/29/25 12:35 == 47.9	4/29/25 17:05 == 34.3	4/29/25 21:35 == 48	4/30/25 2:05 == 34.6
4/29/25 12:40 == 47.9	4/29/25 17:10 == 34.9	4/29/25 21:40 == 48	4/30/25 2:10 == 34.6
4/29/25 12:45 == 47.9	4/29/25 17:15 == 34.8	4/29/25 21:45 == 48	4/30/25 2:15 == 37.2
4/29/25 12:50 == 48.1	4/29/25 17:20 == 34.7	4/29/25 21:50 == 48.1	4/30/25 2:20 == 43.4
4/29/25 12:55 == 48	4/29/25 17:25 == 34.8	4/29/25 21:55 == 48	4/30/25 2:25 == 47.8
4/29/25 13:00 == 48	4/29/25 17:30 == 34.8	4/29/25 22:00 == 48	4/30/25 2:30 == 48
4/29/25 13:05 == 48	4/29/25 17:35 == 34.8	4/29/25 22:05 == 48	4/30/25 2:35 == 48.1
4/29/25 13:10 == 47.9	4/29/25 17:40 == 34.8	4/29/25 22:10 == 47.9	4/30/25 2:40 == 48.1
4/29/25 13:15 == 47.7	4/29/25 17:45 == 34.8	4/29/25 22:15 == 48	4/30/25 2:45 == 48
4/29/25 13:20 == 47.7	4/29/25 17:50 == 34.9	4/29/25 22:20 == 48.1	4/30/25 2:50 == 47.9
4/29/25 13:25 == 47.5	4/29/25 17:55 == 34.8	4/29/25 22:25 == 48.2	4/30/25 2:55 == 47.9
4/29/25 13:30 == 47.6	4/29/25 18:00 == 37.4	4/29/25 22:30 == 47.8	4/30/25 3:00 == 48.1
4/29/25 13:35 == 47.9	4/29/25 18:05 == 45	4/29/25 22:35 == 48.1	4/30/25 3:05 == 48
4/29/25 13:40 == 48.1	4/29/25 18:10 == 48	4/29/25 22:40 == 47.5	4/30/25 3:10 == 47.9
4/29/25 13:45 == 48	4/29/25 18:15 == 47.8	4/29/25 22:45 == 47.9	4/30/25 3:15 == 48.1
4/29/25 13:50 == 48	4/29/25 18:20 == 47.8	4/29/25 22:50 == 47.9	4/30/25 3:20 == 48
4/29/25 13:55 == 48.1	4/29/25 18:25 == 47.5	4/29/25 22:55 == 48	4/30/25 3:25 == 47.8
4/29/25 14:00 == 48.1	4/29/25 18:30 == 47.7	4/29/25 23:00 == 47.9	4/30/25 3:30 == 47.4
4/29/25 14:05 == 48.1	4/29/25 18:35 == 48.1	4/29/25 23:05 == 47.9	4/30/25 3:35 == 48
4/29/25 14:10 == 47.8	4/29/25 18:40 == 48.1	4/29/25 23:10 == 48	4/30/25 3:40 == 47.3
4/29/25 14:15 == 45.4	4/29/25 18:45 == 47.9	4/29/25 23:15 == 43.7	4/30/25 3:45 == 47.8
4/29/25 14:20 == 34.7	4/29/25 18:50 == 47.8	4/29/25 23:20 == 36.9	4/30/25 3:50 == 48
4/29/25 14:25 == 34.8	4/29/25 18:55 == 47.8	4/29/25 23:25 == 33.9	4/30/25 3:55 == 48
4/29/25 14:30 == 34.4	4/29/25 19:00 == 47.9	4/29/25 23:30 == 33.9	4/30/25 4:00 == 47.9
4/29/25 14:35 == 34.4	4/29/25 19:05 == 47.8	4/29/25 23:35 == 33.9	4/30/25 4:05 == 48.1
4/29/25 14:40 == 34.8	4/29/25 19:10 == 47.9	4/29/25 23:40 == 33.8	4/30/25 4:10 == 47.7
4/29/25 14:45 == 34.8	4/29/25 19:15 == 47.9	4/29/25 23:45 == 36.9	4/30/25 4:15 == 44.6
4/29/25 14:50 == 34.8	4/29/25 19:20 == 47.9	4/29/25 23:50 == 43.5	4/30/25 4:20 == 37
4/29/25 14:55 == 34.7	4/29/25 19:25 == 48	4/29/25 23:55 == 47.6	4/30/25 4:25 == 33.9
4/29/25 15:00 == 36.8	4/29/25 19:30 == 48	4/30/25 0:00 == 47.8	4/30/25 4:30 == 33.9
4/29/25 15:05 == 46.1	4/29/25 19:35 == 48.1	4/30/25 0:05 == 47.9	4/30/25 4:35 == 34
4/29/25 15:10 == 47.9	4/29/25 19:40 == 47.4	4/30/25 0:10 == 48	4/30/25 4:40 == 33.9
4/29/25 15:15 == 48	4/29/25 19:45 == 48.1	4/30/25 0:15 == 48	4/30/25 4:45 == 33.8
4/29/25 15:20 == 48.1	4/29/25 19:50 == 48	4/30/25 0:20 == 48	4/30/25 4:50 == 33.8
4/29/25 15:25 == 47.9	4/29/25 19:55 == 47.3	4/30/25 0:25 == 47.7	4/30/25 4:55 == 33.8
4/29/25 15:30 == 48	4/29/25 20:00 == 44.7	4/30/25 0:30 == 48	4/30/25 5:00 == 36.3
4/29/25 15:35 == 47.9	4/29/25 20:05 == 35.4	4/30/25 0:35 == 48.1	4/30/25 5:05 == 42.7
4/29/25 15:40 == 47.6	4/29/25 20:10 == 34.6	4/30/25 0:40 == 48.2	4/30/25 5:10 == 47.6
4/29/25 15:45 == 47.7	4/29/25 20:15 == 34.6	4/30/25 0:45 == 48	4/30/25 5:15 == 48
4/29/25 15:50 == 48	4/29/25 20:20 == 34.6	4/30/25 0:50 == 48.1	4/30/25 5:20 == 48
4/29/25 15:55 == 48.1	4/29/25 20:25 == 34.5	4/30/25 0:55 == 47.9	4/30/25 5:25 == 48
4/29/25 16:00 == 48	4/29/25 20:30 == 34.4	4/30/25 1:00 == 48	4/30/25 5:30 == 47.9
4/29/25 16:05 == 47.9	4/29/25 20:35 == 34.4	4/30/25 1:05 == 48.3	4/30/25 5:35 == 47.8
4/29/25 16:10 == 47.7	4/29/25 20:40 == 34.5	4/30/25 1:10 == 48.2	4/30/25 5:40 == 47.5
4/29/25 16:15 == 47.7	4/29/25 20:45 == 37	4/30/25 1:15 == 47.8	4/30/25 5:45 == 48
4/29/25 16:20 == 47.8	4/29/25 20:50 == 43.8	4/30/25 1:20 == 48	4/30/25 5:50 == 47.9
4/29/25 16:25 == 47.9	4/29/25 20:55 == 47.8	4/30/25 1:25 == 48	4/30/25 5:55 == 47.9

Pumpback Station Discharge (0364)

4/30/25 6:00 == 47.9	4/30/25 10:30 == 48	4/30/25 15:00 == 48	4/30/25 19:30 == 33.5
4/30/25 6:05 == 48.1	4/30/25 10:35 == 47.5	4/30/25 15:05 == 48	4/30/25 19:35 == 39.9
4/30/25 6:10 == 48.1	4/30/25 10:40 == 47.3	4/30/25 15:10 == 48	4/30/25 19:40 == 46.8
4/30/25 6:15 == 48	4/30/25 10:45 == 47.9	4/30/25 15:15 == 46.8	4/30/25 19:45 == 47.9
4/30/25 6:20 == 48.1	4/30/25 10:50 == 47.9	4/30/25 15:20 == 40.4	4/30/25 19:50 == 48
4/30/25 6:25 == 47.5	4/30/25 10:55 == 48	4/30/25 15:25 == 34	4/30/25 19:55 == 48
4/30/25 6:30 == 48	4/30/25 11:00 == 48.1	4/30/25 15:30 == 34.1	4/30/25 20:00 == 48.1
4/30/25 6:35 == 48.1	4/30/25 11:05 == 48	4/30/25 15:35 == 34	4/30/25 20:05 == 48.1
4/30/25 6:40 == 47.6	4/30/25 11:10 == 47.9	4/30/25 15:40 == 34.1	4/30/25 20:10 == 47.8
4/30/25 6:45 == 45	4/30/25 11:15 == 47.9	4/30/25 15:45 == 34	4/30/25 20:15 == 47.5
4/30/25 6:50 == 37.3	4/30/25 11:20 == 47.9	4/30/25 15:50 == 34.1	4/30/25 20:20 == 48
4/30/25 6:55 == 34.4	4/30/25 11:25 == 48.2	4/30/25 15:55 == 34.1	4/30/25 20:25 == 48.1
4/30/25 7:00 == 34.4	4/30/25 11:30 == 48.1	4/30/25 16:00 == 34.1	4/30/25 20:30 == 48.1
4/30/25 7:05 == 34.6	4/30/25 11:35 == 48.1	4/30/25 16:05 == 41.2	4/30/25 20:35 == 48.1
4/30/25 7:10 == 34.6	4/30/25 11:40 == 48.1	4/30/25 16:10 == 46.4	4/30/25 20:40 == 48
4/30/25 7:15 == 34.6	4/30/25 11:45 == 48.1	4/30/25 16:15 == 47.8	4/30/25 20:45 == 47.9
4/30/25 7:20 == 34.6	4/30/25 11:50 == 48	4/30/25 16:20 == 48	4/30/25 20:50 == 47.9
4/30/25 7:25 == 34.6	4/30/25 11:55 == 47.9	4/30/25 16:25 == 47.9	4/30/25 20:55 == 48
4/30/25 7:30 == 36.8	4/30/25 12:00 == 46.5	4/30/25 16:30 == 48	4/30/25 21:00 == 48
4/30/25 7:35 == 42.9	4/30/25 12:05 == 40.5	4/30/25 16:35 == 48	4/30/25 21:05 == 48.1
4/30/25 7:40 == 47.8	4/30/25 12:10 == 34.4	4/30/25 16:40 == 48	4/30/25 21:10 == 47.4
4/30/25 7:45 == 48	4/30/25 12:15 == 34.2	4/30/25 16:45 == 47.9	4/30/25 21:15 == 47.8
4/30/25 7:50 == 47.8	4/30/25 12:20 == 34.3	4/30/25 16:50 == 48	4/30/25 21:20 == 48
4/30/25 7:55 == 47.5	4/30/25 12:25 == 34.3	4/30/25 16:55 == 48.1	4/30/25 21:25 == 48
4/30/25 8:00 == 48.1	4/30/25 12:30 == 34.2	4/30/25 17:00 == 48.1	4/30/25 21:30 == 48.1
4/30/25 8:05 == 48	4/30/25 12:35 == 34.1	4/30/25 17:05 == 48.1	4/30/25 21:35 == 48
4/30/25 8:10 == 47.9	4/30/25 12:40 == 34.1	4/30/25 17:10 == 47.7	4/30/25 21:40 == 47.6
4/30/25 8:15 == 47.9	4/30/25 12:45 == 34.8	4/30/25 17:15 == 47.5	4/30/25 21:45 == 47.8
4/30/25 8:20 == 48	4/30/25 12:50 == 39.6	4/30/25 17:20 == 48	4/30/25 21:50 == 47.9
4/30/25 8:25 == 48	4/30/25 12:55 == 47.4	4/30/25 17:25 == 48.1	4/30/25 21:55 == 48
4/30/25 8:30 == 47.8	4/30/25 13:00 == 48	4/30/25 17:30 == 48	4/30/25 22:00 == 48
4/30/25 8:35 == 48.1	4/30/25 13:05 == 48.1	4/30/25 17:35 == 47.9	4/30/25 22:05 == 40.3
4/30/25 8:40 == 48	4/30/25 13:10 == 47.9	4/30/25 17:40 == 48	4/30/25 22:10 == 34
4/30/25 8:45 == 48.2	4/30/25 13:15 == 48.1	4/30/25 17:45 == 48	4/30/25 22:15 == 33.9
4/30/25 8:50 == 47.8	4/30/25 13:20 == 48.1	4/30/25 17:50 == 48	4/30/25 22:20 == 33.8
4/30/25 8:55 == 47.9	4/30/25 13:25 == 47.7	4/30/25 17:55 == 48.1	4/30/25 22:25 == 33.9
4/30/25 9:00 == 48.1	4/30/25 13:30 == 47.9	4/30/25 18:00 == 48.1	4/30/25 22:30 == 33.8
4/30/25 9:05 == 48	4/30/25 13:35 == 47.8	4/30/25 18:05 == 48	4/30/25 22:35 == 33.8
4/30/25 9:10 == 48	4/30/25 13:40 == 48	4/30/25 18:10 == 47.6	4/30/25 22:40 == 33.8
4/30/25 9:15 == 46	4/30/25 13:45 == 48.1	4/30/25 18:15 == 48	4/30/25 22:45 == 34
4/30/25 9:20 == 36.7	4/30/25 13:50 == 48	4/30/25 18:20 == 47.9	4/30/25 22:50 == 38.1
4/30/25 9:25 == 33.7	4/30/25 13:55 == 47.9	4/30/25 18:25 == 48	4/30/25 22:55 == 47.7
4/30/25 9:30 == 33.8	4/30/25 14:00 == 47.6	4/30/25 18:30 == 48.1	4/30/25 23:00 == 47.9
4/30/25 9:35 == 33.8	4/30/25 14:05 == 47.8	4/30/25 18:35 == 47.5	4/30/25 23:05 == 48
4/30/25 9:40 == 33.8	4/30/25 14:10 == 48.1	4/30/25 18:40 == 47.5	4/30/25 23:10 == 48
4/30/25 9:45 == 33.8	4/30/25 14:15 == 48	4/30/25 18:45 == 48	4/30/25 23:15 == 48.1
4/30/25 9:50 == 33.9	4/30/25 14:20 == 48	4/30/25 18:50 == 39	4/30/25 23:20 == 47.9
4/30/25 9:55 == 33.8	4/30/25 14:25 == 48	4/30/25 18:55 == 34.4	4/30/25 23:25 == 47.9
4/30/25 10:00 == 35.6	4/30/25 14:30 == 48	4/30/25 19:00 == 33.7	4/30/25 23:30 == 48.1
4/30/25 10:05 == 42.2	4/30/25 14:35 == 48.1	4/30/25 19:05 == 33.5	4/30/25 23:35 == 47.9
4/30/25 10:10 == 47.6	4/30/25 14:40 == 47.7	4/30/25 19:10 == 33.6	4/30/25 23:40 == 47.8
4/30/25 10:15 == 47.8	4/30/25 14:45 == 47.6	4/30/25 19:15 == 33.7	4/30/25 23:45 == 48
4/30/25 10:20 == 48	4/30/25 14:50 == 48.1	4/30/25 19:20 == 33.7	4/30/25 23:50 == 47.9
4/30/25 10:25 == 48.1	4/30/25 14:55 == 48.1	4/30/25 19:25 == 33.5	4/30/25 23:55 == 48

Pumpback Station Discharge (0364)