

LORP Synopsis for October 2025

Compliance Comments

Flows were above the minimum flow for the month.

Maintenance

Activities for the month on the Lower Owens River included the following:

- Current metering continues the development of discharge curves at all in-river flow monitoring sites and are used to develop velocity indexing tables.
- Some in-river station measurements have fluctuated as a result of shifting sedimentation in the river, requiring additional indexing to increase the accuracy of measurements.

Operations

- LORP Intake from 80 cfs to 70 cfs on October 8, 2025.
- LORPS Langemann from 11 cfs to 8 cfs on October 16, 2025.
- LORP Intake from 70 cfs to 55 cfs on October 18, 2025.

Waterfowl Area Monthly Report

Synopsis (for Runoff Year 2025-2026)

Implementation of the Interim Management and Monitoring Plan continued, which includes the seasonal flooding regime and a fixed waterfowl acreage goal of 500 acres.

On March 1, 2025 (RY 2024-25) flows to all units were set to 0 cfs.

On September 15, 2025, flows for the Fall season were set as follow: Thibaut Unit – 6.5 cfs, Winterton Unit – 5.5 cfs, and Waggoner Unit – 7.5 cfs.

Flow Rates and Wetted Acreage Summary (for Runoff Year 2025-26)

	Inflow (cfs)	Date Set	Wetted Acreage	Date of Survey
Drew Unit	off	4/16/2021		
Waggoner Unit	off	3/1/2025		
	7.5	9/15/2025		
Winterton Unit	off	3/1/2025		
	5.5	9/15/2025		
Thibaut Unit	off	3/1/2025		
	6.5	9/15/2025		

OCTOBER 2025 IN-RIVER STATION CURRENT METERING SUMMARY

Station	Date	Metered Flow	Station Begin Flow	Station End Flow	Shift Applied	Notes	
LORP Intake	10/28/2025	54.50	54.50	54.50	0	gage height	3.45
At Mazourka Canyon Road	10/28/2025	55.63	55.00	55.00	1	gage height	3.37
At Reinhackle Springs	10/28/2025	55.51	55.70	55.70	0	gage height	3.65

Month: October
Year: 2025

Date	Intake			Blackrock Ditch Return		Billy Lake Return		Mazourka Canyon Road			Locust Ditch Return		Georges Ditch Return		Reinhackle Springs			Alabama Gates Release		Above Pumpstation			Pumpback Discharge		Lange-mann Release to Delta	Weir to Delta	River Daily Avg
	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Flow	Avg Month to Date		
10/01/25	80	80	15	1	1	1	1	75	76	15	0	0	0	0	70	72	15	0	0	57	58	15	46	46	11	0	71
10/02/25	80	80	15	1	1	1	1	74	76	15	0	0	0	0	71	72	15	0	0	57	58	15	46	46	11	0	71
10/03/25	80	80	15	1	1	1	1	73	75	15	0	0	0	0	72	72	15	0	0	56	58	15	45	46	11	0	70
10/04/25	80	80	15	1	1	1	1	73	75	15	0	0	0	0	71	72	15	0	0	56	57	15	45	46	11	0	70
10/05/25	80	80	15	1	1	1	1	74	75	15	0	0	0	0	70	72	15	0	0	56	57	15	45	45	11	0	70
10/06/25	80	80	15	1	1	1	1	76	75	15	0	0	0	0	71	71	15	0	0	58	57	15	47	46	11	0	71
10/07/25	80	80	15	1	1	1	1	76	75	15	0	0	0	0	73	71	15	0	0	58	57	15	47	46	11	0	72
10/08/25	74	80	15	1	1	1	1	75	75	15	0	0	0	0	73	72	15	0	0	58	57	15	47	46	11	0	70
10/09/25	69	79	15	1	1	1	1	74	74	15	0	0	0	0	71	72	15	0	0	58	57	15	47	46	11	0	68
10/10/25	70	78	15	1	1	1	1	67	74	15	0	0	0	0	73	72	15	0	0	57	57	15	46	46	11	0	67
10/11/25	70	77	15	1	1	1	1	66	73	15	0	0	0	0	67	71	15	0	0	56	57	15	45	46	11	0	65
10/12/25	70	77	15	1	1	1	1	65	73	15	0	0	0	0	65	71	15	0	0	55	57	15	44	46	11	0	64
10/13/25	70	76	15	1	1	1	1	65	72	15	0	0	0	0	64	70	15	0	0	57	57	15	46	46	11	0	64
10/14/25	70	76	15	1	1	1	1	66	71	15	0	0	0	0	67	70	15	0	0	58	57	15	47	46	11	0	65
10/15/25	69	75	15	1	1	1	1	68	71	15	0	0	0	0	67	70	15	0	0	59	57	15	48	46	11	0	66
10/16/25	69	74	15	1	1	1	1	67	71	15	0	0	0	0	68	70	15	0	0	61	57	15	48	46	9	4	66
10/17/25	69	73	15	1	1	1	1	65	70	15	0	0	0	0	69	69	15	0	0	66	58	15	48	46	8	10	67
10/18/25	62	72	15	1	1	1	1	65	69	15	0	0	0	0	67	69	15	0	0	62	58	15	48	46	8	6	64
10/19/25	56	71	15	1	1	1	1	62	69	15	0	0	0	0	65	69	15	0	0	60	59	15	48	46	8	4	61
10/20/25	56	69	15	1	1	1	1	55	67	15	0	0	0	0	63	68	15	0	0	59	59	15	48	47	8	3	58
10/21/25	56	67	15	1	1	1	1	53	66	15	0	0	0	0	59	67	15	0	0	59	59	15	48	47	8	3	57
10/22/25	56	66	15	1	1	1	1	52	64	15	0	0	0	0	57	66	15	0	0	60	59	15	48	47	8	4	56
10/23/25	55	64	15	1	1	1	1	51	63	15	0	0	0	0	55	65	15	0	0	58	59	15	48	47	8	2	55
10/24/25	55	64	15	1	1	1	1	51	61	15	0	0	0	0	55	64	15	0	0	57	59	15	48	47	8	1	55
10/25/25	56	63	15	1	1	1	1	51	60	15	0	0	0	0	53	63	15	0	0	56	59	15	48	47	8	0	54
10/26/25	55	62	15	1	1	1	1	51	59	15	0	0	0	0	52	62	15	0	0	53	59	15	45	47	8	0	53
10/27/25	55	61	15	1	1	1	1	50	58	15	0	0	0	0	52	61	15	0	0	50	58	15	42	47	8	0	52
10/28/25	56	60	15	1	1	1	1	56	58	15	0	0	0	0	56	60	15	0	0	49	58	15	41	46	8	0	54
10/29/25	55	59	15	1	1	1	1	56	57	15	0	0	0	0	56	60	15	0	0	48	57	15	40	46	8	0	54
10/30/25	56	58	15	1	1	1	1	55	56	15	0	0	0	0	57	59	15	0	0	48	56	15	40	46	8	0	54
10/31/25	55	57	15	1	1	1	1	56	55	15	0	0	0	0	56	58	15	0	0	48	56	15	40	46	8	0	54
Monthly Avg	66						63						64			56						62					

Lower Owens River Project Flow Report for 10/01/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			80	80	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			75	76	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	1			
Reinhackle Springs			70	72	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			57	58	15
Pump Station			46	47	
Langemann Gate to Delta			11	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			70	71	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 09/24/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.54 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/02/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			80	80	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			74	76	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	1	1			
Reinhackle Springs			71	72	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			57	58	15
Pump Station			46	47	
Langemann Gate to Delta			11	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			70	71	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 09/24/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.54 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/03/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			80	80	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			73	75	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	1	1			
Reinhackle Springs			72	72	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			56	58	15
Pump Station			45	47	
Langemann Gate to Delta			11	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			70	71	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 09/24/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.54 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/04/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			80	80	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			73	75	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	1	1			
Reinhackle Springs			71	72	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			56	57	15
Pump Station			45	46	
Langemann Gate to Delta			11	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			70	71	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 09/24/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.54 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/05/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			80	80	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			74	75	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	1	1			
Reinhackle Springs			70	72	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			56	57	15
Pump Station			45	46	
Langemann Gate to Delta			11	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			70	71	

Pump Station Month-to-Date Average Flow 45 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 09/24/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.54 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/06/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			80	80	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	1			
Mazourka Canyon Road			76	75	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	1	1			
Reinhackle Springs			71	71	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			58	57	15
Pump Station			47	46	
Langemann Gate to Delta			11	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			71	71	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 09/24/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.54 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/07/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			80	80	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			76	75	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	1	1			
Reinhackle Springs			73	71	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			58	57	15
Pump Station			47	46	
Langemann Gate to Delta			11	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			72	71	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.52 ft	(Last Collected: 09/24/2025)
Lower Twin Lake Gage Read	2.39 ft	
Goose Lake Gage Read	2.54 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/08/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			74	80	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			75	75	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	1	1			
Reinhackle Springs			73	72	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			58	57	15
Pump Station			47	46	
Langemann Gate to Delta			11	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			70	71	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 10/08/2025)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/09/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			69	79	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			74	74	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			71	72	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			58	57	15
Pump Station			47	46	
Langemann Gate to Delta			11	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			68	70	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 10/08/2025)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/10/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			70	78	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			67	74	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			73	72	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			57	57	15
Pump Station			46	46	
Langemann Gate to Delta			11	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			67	70	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 10/08/2025)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/11/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			70	77	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			66	73	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			67	71	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			56	57	15
Pump Station			45	46	
Langemann Gate to Delta			11	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			65	70	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 10/08/2025)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/12/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			70	77	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			65	73	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			65	71	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			55	57	15
Pump Station			44	46	
Langemann Gate to Delta			11	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			64	69	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 10/08/2025)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/13/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			70	76	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			65	72	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			64	70	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			57	57	15
Pump Station			46	46	
Langemann Gate to Delta			11	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			64	69	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 10/08/2025)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/14/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			70	76	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			66	71	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			67	70	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			58	57	15
Pump Station			47	46	
Langemann Gate to Delta			11	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			65	68	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 10/08/2025)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/15/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			69	75	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			68	71	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			67	70	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			59	57	15
Pump Station			48	46	
Langemann Gate to Delta			11	11	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			66	68	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 10/08/2025)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/16/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			69	74	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.4	1			
Mazourka Canyon Road			67	71	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			68	70	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			61	57	15
Pump Station			48	46	
Langemann Gate to Delta			9	11	
Weir to Delta			4	0	
LORP In Channel Average Flow ²			66	68	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 10/08/2025)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/17/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			69	73	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			65	70	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			69	69	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			66	58	15
Pump Station			48	46	
Langemann Gate to Delta			8	11	
Weir to Delta			10	1	
LORP In Channel Average Flow ²			67	68	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 10/08/2025)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/18/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			62	72	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			65	69	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			67	69	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			62	58	15
Pump Station			48	47	
Langemann Gate to Delta			8	10	
Weir to Delta			6	1	
LORP In Channel Average Flow ²			64	67	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 10/08/2025)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/19/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			56	71	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			62	69	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			65	69	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			60	59	15
Pump Station			48	47	
Langemann Gate to Delta			8	10	
Weir to Delta			4	2	
LORP In Channel Average Flow ²			61	67	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 10/08/2025)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/20/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			56	69	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			55	67	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			63	68	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			59	59	15
Pump Station			48	47	
Langemann Gate to Delta			8	10	
Weir to Delta			3	2	
LORP In Channel Average Flow ²			58	66	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 10/08/2025)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/21/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			56	67	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			53	66	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			59	67	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			59	59	15
Pump Station			48	47	
Langemann Gate to Delta			8	10	
Weir to Delta			3	2	
LORP In Channel Average Flow ²			57	65	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.53 ft	(Last Collected: 10/08/2025)
Lower Twin Lake Gage Read	2.22 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/22/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			56	66	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			52	64	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			57	66	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			60	59	15
Pump Station			48	47	
Langemann Gate to Delta			8	10	
Weir to Delta			4	2	
LORP In Channel Average Flow ²			56	64	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.60 ft	(Last Collected: 10/22/2025)
Lower Twin Lake Gage Read	2.43 ft	
Goose Lake Gage Read	2.60 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/23/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			55	64	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			51	63	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			55	65	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			58	59	15
Pump Station			48	47	
Langemann Gate to Delta			8	9	
Weir to Delta			2	2	
LORP In Channel Average Flow ²			55	63	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.60 ft	(Last Collected: 10/22/2025)
Lower Twin Lake Gage Read	2.43 ft	
Goose Lake Gage Read	2.60 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/24/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			55	64	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			51	61	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			55	64	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			57	59	15
Pump Station			48	47	
Langemann Gate to Delta			8	9	
Weir to Delta			1	2	
LORP In Channel Average Flow ²			54	62	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.60 ft	(Last Collected: 10/22/2025)
Lower Twin Lake Gage Read	2.43 ft	
Goose Lake Gage Read	2.60 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/25/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			56	63	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.4	1			
Mazourka Canyon Road			51	60	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			53	63	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			56	59	15
Pump Station			48	47	
Langemann Gate to Delta			8	9	
Weir to Delta			0	2	
LORP In Channel Average Flow ²			54	61	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.60 ft	(Last Collected: 10/22/2025)
Lower Twin Lake Gage Read	2.43 ft	
Goose Lake Gage Read	2.60 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/26/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			55	62	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.4	1			
Mazourka Canyon Road			51	59	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			52	62	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			53	59	15
Pump Station			45	47	
Langemann Gate to Delta			8	9	
Weir to Delta			0	2	
LORP In Channel Average Flow ²			53	60	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.60 ft	(Last Collected: 10/22/2025)
Lower Twin Lake Gage Read	2.43 ft	
Goose Lake Gage Read	2.60 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/27/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			55	61	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			50	58	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			52	61	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			50	58	15
Pump Station			42	47	
Langemann Gate to Delta			8	9	
Weir to Delta			0	2	
LORP In Channel Average Flow ²			52	59	

Pump Station Month-to-Date Average Flow 47 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.60 ft	(Last Collected: 10/22/2025)
Lower Twin Lake Gage Read	2.43 ft	
Goose Lake Gage Read	2.60 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/28/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			56	60	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			56	58	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			56	60	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			49	58	15
Pump Station			41	47	
Langemann Gate to Delta			8	8	
Weir to Delta			0	2	
LORP In Channel Average Flow ²			54	59	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.60 ft	(Last Collected: 10/22/2025)
Lower Twin Lake Gage Read	2.43 ft	
Goose Lake Gage Read	2.60 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/29/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			55	59	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			56	57	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			56	60	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			48	57	15
Pump Station			40	46	
Langemann Gate to Delta			8	8	
Weir to Delta			0	2	
LORP In Channel Average Flow ²			54	58	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.60 ft	(Last Collected: 10/22/2025)
Lower Twin Lake Gage Read	2.43 ft	
Goose Lake Gage Read	2.60 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/30/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			56	58	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	0.8	1			
Mazourka Canyon Road			55	56	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			57	59	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			48	56	15
Pump Station			40	46	
Langemann Gate to Delta			8	8	
Weir to Delta			0	2	
LORP In Channel Average Flow ²			54	57	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.60 ft	(Last Collected: 10/22/2025)
Lower Twin Lake Gage Read	2.43 ft	
Goose Lake Gage Read	2.60 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 10/31/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			55	57	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			56	55	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			56	58	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			48	56	15
Pump Station			40	45	
Langemann Gate to Delta			8	8	
Weir to Delta			0	2	
LORP In Channel Average Flow ²			54	56	

Pump Station Month-to-Date Average Flow 46 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	6.5 cfs	09/15/2025
Winterton	237 Acres	03/01/2025	5.5 cfs	09/15/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	7.5 cfs	09/15/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.60 ft	(Last Collected: 10/22/2025)
Lower Twin Lake Gage Read	2.43 ft	
Goose Lake Gage Read	2.60 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Courtnie Cappello

DATE: October 7, 2025

REQUESTED BY: Tony Tillemans x32259

FLOW CHANGE LOCATION **LORP Intake**

START DATE: Wednesday, October 8, 2025 TIME: morning

CHANGE FLOW: From: 80 cfs To: 70 cfs

To maintain required flows to the LORP, monitor and make adjustments to the Aqueduct Intake gates for at least one day following this flow change.

C:	Adam Perez	Ben Butler
	Eric Tillemans	Jason Olin
	Forest Mathieu	Bruce Peterson
	Ryan Yeager	Gary Reiser
	Joe Bowling	Chad Lamacchia

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Miles Maillet/Ian Keller

DATE: October 16, 2025

REQUESTED BY: Tony Tillemans x32259

FLOW CHANGE LOCATION **Langemann Gate at Pumpstation**

START DATE: Thursday, October 16, 2025 TIME: morning

CHANGE FLOW: FROM: 11 cfs TO: 8 cfs at LORPS Langemann

C: Adam Perez
Eric Tillemans
Chad Lamacchia
Ben Arcularius

Ben Butler
Jason Olin
Gary Reiser
Bruce Peterson

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Courtnie Cappello

DATE: October 17, 2025

REQUESTED BY: Tony Tillemans x32259

FLOW CHANGE LOCATION **LORP Intake**

START DATE: Saturday, October 18, 2025 TIME: morning

CHANGE FLOW: From: 70 cfs To: 55 cfs

To maintain required flows to the LORP, monitor and make adjustments to the Aqueduct Intake gates for at least one day following this flow change.

C: Adam Perez
Eric Tillemans
Forest Mathieu
Ryan Yeager
Joe Bowling

Ben Butler
Jason Olin
Bruce Peterson
Gary Reiser
Chad Lamacchia

Quality Assurance and Calibration Procedures

The Los Angeles Department of Water and Power has a set standard to assure quality of all hydrological data collected. Procedures used to QA data vary based on the type of data collected and the device used to measure flow.

Data collected from sites utilizing area velocity flow meters are electronically monitored continuously. Sites are physically visited most days of the week to assure debris or vandalism hasn't affected the reading. Errors in the data collected may arise from several sources:

1. The transducers which detect the stage height and velocities have a tendency to drift.
2. Power outages occur occasionally thereby preventing the recording of data to the data loggers.
3. Occasionally the data loggers themselves malfunction.
4. Data can be lost or corrupted when it is transferred from the data loggers to the laptop.

Errors in discharge can originate from the instability of the relationship between velocity and stage height. This relationship varies temporally. It is affected by changes in the streambed that results from the flow of water over the bed, such as scour and fill, aquatic growth, ice, debris, or bed roughness.

To compensate for changes in the constantly shifting conditions multiple current meter measurements at each location per USGS standards are conducted per month. The current meter shots are taken at 2 foot intervals horizontally across the lined sections or 1 foot intervals at the sites where the measurements are taken in culverts. In each vertical section two separate measurements are taken (0.2 and 0.8) of the depth to achieve the best velocity average in the vertical. These vertical discharges are then added together to obtain a total flow in the section. The current meter data is logged in an on-board computer tracking the measurements as taken. That data is then extracted from the on-board computer to a PC using the FlowPack software that allows analysis of the data for erroneous measurements and is then converted to an Excel spreadsheet for ease of storage and printing. See Examples 1 – 3 for printout of software used to validate the current meter data.

Current meter data is used to develop velocity index tables. The tables require a minimum of 6 meter shots. After a table has been developed it is then downloaded into the on-site SonTek software which takes into account any variables within the meter section and applies any shifts to the discharge.

Data is collected and logged every 10 minutes utilizing SonTek area velocity flow meters. The data is downloaded from the meters once per month utilizing software provided by SonTek. The software "ViewArgonaut" gives us the ability to check items relevant to the performance of the meter. Battery voltage, beam strength, noise ratios, depth, and cell distance. (See Example 4) The software provides a trend of the data collected and displays it for quick comparisons, flagging discrepancies, one day at a time. Utilizing the ViewArgonaut software monthly reports are generated and the data is

reviewed. Using the current meter data collected during the month shifts are applied to the discharge to assure accuracy.

Augmentation Flows

Flows at several of the augmentation points are measured using weirs and flumes at sites that were pre-existing. Billy Lake has a one foot Parshall flume, Locust and Georges Returns have three foot weirs installed. All have stilling wells with dataloggers installed. The water surface elevation in the stillwell is measured each time the site is visited and verified it matches the staff gage for correct water depth through the measuring device. The still wells are flushed once every two months to assure the communication line is open and free of debris. The gage height data is logged on a module every 15 minutes. The modules are changed and processed every two weeks. Software used to process the data gives an hourly average gage and converts it to flow. It also gives the maximum and minimum flows for each day and time stamps it. The data is reviewed for any discrepancies which can be caused as a result of debris plugging the measuring device, a plugged stillwell, low batteries, etc.

SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:

[Open a FlowTracker file](#)[Open many FlowTracker files/folders](#)

The current export settings are:

- ☒ Show Discharge Summary Report
- ☒ Export ASCII Discharge file (DIS)
- ☒ Export ASCII Control file (CTL)
- ☒ Export ASCII Summary file (SUM)
- ☒ Export ASCII Data file (DAT)
- ☒ Export FlowPack file (FPX)
- ☒ Put Headers on ASCII files

[Connect to a FlowTracker](#)

To download data and run diagnostics

[Program Settings](#)[Quality Control Settings](#)[Show User's Manual](#)[Show Technical Manual](#)[Show Quick Start](#)[About FlowTracker](#)

English



A YSI Environmental Company

070706.0RABR.LOR.WAD

Discharge Measurement Summary

Date Generated: Thu Sep 27 2007

File Information

File Name 070706.0RABR.LOR.WAD
Start Date and Time 2007/07/06 07:48:17

Site Details

Site Name ORABR
Operator(s) DJT

System Information

Sensor Type FlowTracker
Serial # P1685
CPU Firmware Version 3.2
Software Ver 2.11

Units

(English Units)

Distance ft
Velocity ft/s
Area ft²
Discharge cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.1%	0.5%
Velocity	0.3%	1.4%
Width	0.1%	0.1%
Method	0.8%	-
# Stations	1.6%	-
Overall	2.1%	1.8%

Summary

Averaging Int.	40	# Stations	32
Start Edge	REW	Total Width	48.100
Mean SNR	18.7 dB	Total Area	69.016
Mean Temp	73.68 °F	Mean Depth	1.435
Disch. Equation	Mid-Section	Mean Velocity	0.6419
		Total Discharge	44.3025

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	07:48	23.60	None	0.000	0.0	0.0	0.0000	1.00	0.0000	0.000	0.0000	0.0
1	07:48	24.60	0.6	0.360	0.6	0.144	0.2762	1.00	0.2762	0.360	0.0994	0.2
2	07:50	25.60	0.6	0.640	0.6	0.256	0.5102	1.00	0.5102	0.640	0.3266	0.7
3	07:51	26.60	0.6	0.880	0.6	0.352	0.5938	1.00	0.5938	0.880	0.5225	1.2
4	07:52	27.60	0.6	1.180	0.6	0.472	0.6257	1.00	0.6257	1.180	0.7383	1.7
5	07:54	28.60	0.6	1.390	0.6	0.556	0.6302	1.00	0.6302	1.390	0.8761	2.0
6	07:55	29.60	0.2/0.8	1.520	0.2	1.216	0.8130	1.00	0.7078	1.520	1.0759	2.4
6	07:56	29.60	0.2/0.8	1.520	0.8	0.304	0.6027					
7	07:58	30.60	0.8/0.2	1.690	0.2	1.352	0.8468	1.00	0.7664	1.690	1.2952	2.9
7	07:57	30.60	0.8/0.2	1.690	0.8	0.338	0.6860					
8	07:59	31.60	0.2/0.8	1.700	0.2	1.360	0.8146	1.00	0.7037	2.040	1.4357	3.2
8	08:00	31.60	0.2/0.8	1.700	0.8	0.340	0.5928					
9	08:03	33.00	0.8/0.2	1.680	0.2	1.344	0.8383	1.00	0.7408	2.016	1.4935	3.4
9	08:01	33.00	0.8/0.2	1.680	0.8	0.336	0.6434					
10	08:05	34.00	0.2/0.8	1.600	0.2	1.280	0.8724	1.00	0.7398	2.400	1.7757	4.0
10	08:06	34.00	0.2/0.8	1.600	0.8	0.320	0.6073					
11	08:08	36.00	0.8/0.2	1.520	0.2	1.216	0.8186	1.00	0.6995	3.040	2.1264	4.8
11	08:07	36.00	0.8/0.2	1.520	0.8	0.304	0.5804					
12	08:09	38.00	0.2/0.8	1.500	0.2	1.200	0.8957	1.00	0.7461	3.000	2.2382	5.1
12	08:11	38.00	0.2/0.8	1.500	0.8	0.300	0.5965					
13	08:12	40.00	0.2/0.8	1.490	0.2	1.192	0.8245	1.00	0.6321	2.980	1.8837	4.3
13	08:13	40.00	0.2/0.8	1.490	0.8	0.298	0.4396					
14	08:15	42.00	0.2/0.8	1.510	0.2	1.208	0.8514	1.00	0.7548	3.020	2.2791	5.1
14	08:16	42.00	0.2/0.8	1.510	0.8	0.302	0.6581					
15	08:18	44.00	0.8/0.2	1.600	0.2	1.280	0.8278	1.00	0.7026	3.200	2.2484	5.1
15	08:17	44.00	0.8/0.2	1.600	0.8	0.320	0.5774					
16	08:19	46.00	0.2/0.8	1.620	0.2	1.296	0.8018	1.00	0.6916	3.240	2.2409	5.1
16	08:20	46.00	0.2/0.8	1.620	0.8	0.324	0.5814					
17	08:22	48.00	0.8/0.2	1.700	0.2	1.360	0.8396	1.00	0.7756	3.400	2.6372	6.0
17	08:21	48.00	0.8/0.2	1.700	0.8	0.340	0.7116					
18	08:23	50.00	0.2/0.8	1.800	0.2	1.440	0.9016	1.00	0.8251	3.600	2.9703	6.7
18	08:24	50.00	0.2/0.8	1.800	0.8	0.360	0.7487					
19	08:26	52.00	0.8/0.2	1.680	0.2	1.344	0.8271	1.00	0.7269	3.360	2.4425	5.5
19	08:25	52.00	0.8/0.2	1.680	0.8	0.336	0.6266					
20	08:27	54.00	0.2/0.8	1.780	0.2	1.424	0.7795	1.00	0.6763	3.560	2.4076	5.4
20	08:28	54.00	0.2/0.8	1.780	0.8	0.356	0.5732					
21	08:30	56.00	0.8/0.2	1.820	0.2	1.456	0.7329	1.00	0.6097	3.640	2.2193	5.0
21	08:29	56.00	0.8/0.2	1.820	0.8	0.364	0.4865					
22	08:32	58.00	0.2/0.8	1.820	0.2	1.456	0.7123	1.00	0.5540	3.640	2.0163	4.6
22	08:34	58.00	0.2/0.8	1.820	0.8	0.364	0.3957					
23	08:36	60.00	0.8/0.2	1.800	0.2	1.440	0.6949	1.00	0.6017	3.600	2.1660	4.9
23	08:35	60.00	0.8/0.2	1.800	0.8	0.360	0.5085					

SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:

[Open a FlowTracker file](#)[Open many FlowTracker files/folders](#)**The current export settings are:**

- ☒ Show Discharge Summary Report
- ☒ Export ASCII Discharge file (DIS)
- ☒ Export ASCII Control file (CTL)
- ☒ Export ASCII Summary file (SUM)
- ☒ Export ASCII Data file (DAT)
- ☒ Export FlowPack file (FPX)
- ☒ Put Headers on ASCII files

[Connect to a FlowTracker](#)

To download data and run diagnostics




[Program Settings](#)[Quality Control Settings](#)[Show User's Manual](#)[Show Technical Manual](#)[Show Quick Start](#)[About FlowTracker](#)

English



A YSI Environmental Company

070706.0RABR.LOR.WAD




Quality Control

St	Loc	%Dep	Message
13	40.00	0.8	High standard error: 0.024

Automatic Quality Control Test (BeamCheck)

Fri Jul 6 07:47:10 PDT 2007



SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:

[Open a FlowTracker file](#)[Open many FlowTracker files/folders](#)**The current export settings are:**

- ☒ Show Discharge Summary Report
- ☒ Export ASCII Discharge file (DIS)
- ☒ Export ASCII Control file (CTL)
- ☒ Export ASCII Summary file (SUM)
- ☒ Export ASCII Data file (DAT)
- ☒ Export FlowPack file (FPX)
- ☒ Put Headers on ASCII files

[Connect to a FlowTracker](#)

To download data and run diagnostics




[Program Settings](#)[Quality Control Settings](#)[Show User's Manual](#)[Show Technical Manual](#)[Show Quick Start](#)[About FlowTracker](#)

English



A YSI Environmental Company


070706.0RABR.LOR.WAD





Quality Control

St	Loc	%Dep	Message
13	40.00	0.8	High standard error: 0.024

Automatic Quality Control Test (BeamCheck)



FileName: BROR_070801_a.arg (Argonaut- SW 3000 kHz)



System	Argonaut-SW
Frequency	3000 kHz
File	BROR_070801_a
File Size	65.18 kB
Sample No	1
Sample Date	02/07/2007
Sample Time	13:28:38
Time Interval	180

Velocity Data:	
V1/X/E(cm/s)	27.8
V2/Y/N(cm/s)	2.4
V3/Z/U(cm/s)	--
Speed (cm/s)	27.9
Direction(deg)	85.1

Discharge Summary:	
V Beam (m)	0.426
Stage (m)	1.304
VMean (cm/s)	22.7
Flow (cfs)	50.21
Area (m2)	6.26
Vol (acre-ft)	0.7

Diagnostic Data:	
SNR1 (dB)	61
SNR2 (dB)	61
SNR3 (dB)	--
StErr1 (cm/s)	0.9
StErr2 (cm/s)	0.8
StErr3 (cm/s)	--
Mean StDev	0.9
Battery (V)	12.4

Party: BRP BLP	Width: 29.9 ft	Processed by: BJA
Boat/Motor: BOAT	Area: 130 ft²	Mean Velocity: 0.421 ft/s
Gage Height: 5.13 ft	G.H.Change: 0.000 ft	Discharge: 54.5 ft³/s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.00°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft²	Diff.: 0.000%
Depth: Composite (BT)	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:		ADCP:	
BT 3-Beam Solution: YES	Max. Vel.: 1.90 ft/s	Type/Freq.: StreamPro / 2000 kHz	
WT 3-Beam Solution: YES	Max. Depth: 5.25 ft	Serial #: 2370	Firmware: 31.17
BT Error Vel.: 0.33 ft/s	Mean Depth: 4.35 ft	Bin Size: 6 cm	Blank: 3 cm
WT Error Vel.: 1.15 ft/s	% Meas.: 66.03	BT Mode: 10	BT Pings: 2
BT Up Vel.: 1.00 ft/s	Water Temp.: None	WT Mode: 12	WT Pings: 6
WT Up Vel.: 1.64 ft/s	ADCP Temp.: 58.5 °F		
Use Weighted Mean Depth: YES			

Performed Diag. Test: NO
 Performed Moving Bed Test: NO
 Performed Compass Calibration: NO Evaluation: NO
 Meas. Location: BRIDGE

Project Name: 251028 intake_0.mmt
 Software: 2.26.00.04

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
001	R	2	2	36	5.62	35.1	5.79	2.86	3.88	53.2	28	124	10:34	10:35	0.69	0.43	14	3
003	R	2	2	40	5.93	37.2	6.46	2.65	3.81	56.0	32	141	10:36	10:36	0.62	0.40	28	3
004	L	2	2	32	5.76	34.9	6.22	1.17	4.27	52.3	30	128	10:37	10:37	0.71	0.41	0	1
005	R	2	2	41	5.93	36.8	5.76	3.28	4.66	56.5	29	127	10:37	10:38	0.56	0.45	24	3
Mean		2	2	37	5.81	36.0	6.06	2.49	4.16	54.5	30	130	Total	00:04	0.64	0.42	16	2
SDev		0	0	4	0.154	1.16	0.342	0.922	0.392	2.03	1.6	7.7			0.07	0.02		
SD/M		0.0%	0.0%	11.1%	2.6%	3.2%	5.6%	37.0%	9.4%	3.7%	5.5%	5.9%			10.2%	5.1%		

Remarks:

Blackrock Return Ditch

Station 0208

Date	Flow (cfs)
10/1/2025	1.19
10/2/2025	1.16
10/3/2025	0.97
10/4/2025	1.07
10/5/2025	1.10
10/6/2025	1.00
10/7/2025	1.01
10/8/2025	1.11
10/9/2025	1.31
10/10/2025	1.28
10/11/2025	1.28
10/12/2025	1.33
10/13/2025	1.35
10/14/2025	1.35
10/15/2025	1.42
10/16/2025	1.39
10/17/2025	1.38
10/18/2025	1.38
10/19/2025	1.44
10/20/2025	1.46
10/21/2025	1.40
10/22/2025	1.27
10/23/2025	1.25
10/24/2025	1.29
10/25/2025	1.30
10/26/2025	1.26
10/27/2025	1.26
10/28/2025	1.33
10/29/2025	1.33
10/30/2025	1.30
10/31/2025	1.30

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/1/2025	12:00:00 AM	0.49
10/1/2025	12:15:00 AM	0.49
10/1/2025	12:30:00 AM	0.49
10/1/2025	12:45:00 AM	0.49
10/1/2025	1:00:00 AM	0.49
10/1/2025	1:15:00 AM	0.49
10/1/2025	1:30:00 AM	0.49
10/1/2025	1:45:00 AM	0.49
10/1/2025	2:00:00 AM	0.49
10/1/2025	2:15:00 AM	0.49
10/1/2025	2:30:00 AM	0.49
10/1/2025	2:45:00 AM	0.49
10/1/2025	3:00:00 AM	0.49
10/1/2025	3:15:00 AM	0.49
10/1/2025	3:30:00 AM	0.49
10/1/2025	3:45:00 AM	0.5
10/1/2025	4:00:00 AM	0.5
10/1/2025	4:15:00 AM	0.5
10/1/2025	4:30:00 AM	0.5
10/1/2025	4:45:00 AM	0.5
10/1/2025	5:00:00 AM	0.5
10/1/2025	5:15:00 AM	0.5
10/1/2025	5:30:00 AM	0.5
10/1/2025	5:45:00 AM	0.5
10/1/2025	6:00:00 AM	0.5
10/1/2025	6:15:00 AM	0.5
10/1/2025	6:30:00 AM	0.5
10/1/2025	6:45:00 AM	0.5
10/1/2025	7:00:00 AM	0.5
10/1/2025	7:15:00 AM	0.5
10/1/2025	7:30:00 AM	0.5
10/1/2025	7:45:00 AM	0.5
10/1/2025	8:00:00 AM	0.5
10/1/2025	8:15:00 AM	0.5
10/1/2025	8:30:00 AM	0.5
10/1/2025	8:45:00 AM	0.5
10/1/2025	9:00:00 AM	0.5
10/1/2025	9:15:00 AM	0.5
10/1/2025	9:30:00 AM	0.5
10/1/2025	9:45:00 AM	0.5
10/1/2025	10:00:00 AM	0.5
10/1/2025	10:15:00 AM	0.5
10/1/2025	10:30:00 AM	0.5
10/1/2025	10:45:00 AM	0.5
10/1/2025	11:00:00 AM	0.5
10/1/2025	11:15:00 AM	0.5

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/1/2025	11:30:00 AM	0.5
10/1/2025	11:45:00 AM	0.5
10/1/2025	12:00:00 PM	0.5
10/1/2025	12:15:00 PM	0.5
10/1/2025	12:30:00 PM	0.5
10/1/2025	12:45:00 PM	0.5
10/1/2025	1:00:00 PM	0.5
10/1/2025	1:15:00 PM	0.5
10/1/2025	1:30:00 PM	0.5
10/1/2025	1:45:00 PM	0.5
10/1/2025	2:00:00 PM	0.5
10/1/2025	2:15:00 PM	0.5
10/1/2025	2:30:00 PM	0.5
10/1/2025	2:45:00 PM	0.5
10/1/2025	3:00:00 PM	0.5
10/1/2025	3:15:00 PM	0.5
10/1/2025	3:30:00 PM	0.5
10/1/2025	3:45:00 PM	0.5
10/1/2025	4:00:00 PM	0.5
10/1/2025	4:15:00 PM	0.5
10/1/2025	4:30:00 PM	0.5
10/1/2025	4:45:00 PM	0.5
10/1/2025	5:00:00 PM	0.5
10/1/2025	5:15:00 PM	0.5
10/1/2025	5:30:00 PM	0.5
10/1/2025	5:45:00 PM	0.5
10/1/2025	6:00:00 PM	0.5
10/1/2025	6:15:00 PM	0.5
10/1/2025	6:30:00 PM	0.5
10/1/2025	6:45:00 PM	0.5
10/1/2025	7:00:00 PM	0.5
10/1/2025	7:15:00 PM	0.5
10/1/2025	7:30:00 PM	0.5
10/1/2025	7:45:00 PM	0.5
10/1/2025	8:00:00 PM	0.5
10/1/2025	8:15:00 PM	0.5
10/1/2025	8:30:00 PM	0.5
10/1/2025	8:45:00 PM	0.5
10/1/2025	9:00:00 PM	0.5
10/1/2025	9:15:00 PM	0.5
10/1/2025	9:30:00 PM	0.5
10/1/2025	9:45:00 PM	0.5
10/1/2025	10:00:00 PM	0.5
10/1/2025	10:15:00 PM	0.5
10/1/2025	10:30:00 PM	0.5
10/1/2025	10:45:00 PM	0.5

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/1/2025	11:00:00 PM	0.5
10/1/2025	11:15:00 PM	0.5
10/1/2025	11:30:00 PM	0.5
10/1/2025	11:45:00 PM	0.5
10/2/2025	12:00:00 AM	0.5
10/2/2025	12:15:00 AM	0.5
10/2/2025	12:30:00 AM	0.5
10/2/2025	12:45:00 AM	0.5
10/2/2025	1:00:00 AM	0.5
10/2/2025	1:15:00 AM	0.5
10/2/2025	1:30:00 AM	0.5
10/2/2025	1:45:00 AM	0.5
10/2/2025	2:00:00 AM	0.5
10/2/2025	2:15:00 AM	0.5
10/2/2025	2:30:00 AM	0.5
10/2/2025	2:45:00 AM	0.5
10/2/2025	3:00:00 AM	0.5
10/2/2025	3:15:00 AM	0.5
10/2/2025	3:30:00 AM	0.5
10/2/2025	3:45:00 AM	0.5
10/2/2025	4:00:00 AM	0.5
10/2/2025	4:15:00 AM	0.5
10/2/2025	4:30:00 AM	0.5
10/2/2025	4:45:00 AM	0.5
10/2/2025	5:00:00 AM	0.5
10/2/2025	5:15:00 AM	0.5
10/2/2025	5:30:00 AM	0.5
10/2/2025	5:45:00 AM	0.5
10/2/2025	6:00:00 AM	0.5
10/2/2025	6:15:00 AM	0.5
10/2/2025	6:30:00 AM	0.5
10/2/2025	6:45:00 AM	0.5
10/2/2025	7:00:00 AM	0.5
10/2/2025	7:15:00 AM	0.5
10/2/2025	7:30:00 AM	0.5
10/2/2025	7:45:00 AM	0.5
10/2/2025	8:00:00 AM	0.5
10/2/2025	8:15:00 AM	0.5
10/2/2025	8:30:00 AM	0.5
10/2/2025	8:45:00 AM	0.5
10/2/2025	9:00:00 AM	0.5
10/2/2025	9:15:00 AM	0.5
10/2/2025	9:30:00 AM	0.5
10/2/2025	9:45:00 AM	0.5
10/2/2025	10:00:00 AM	0.49
10/2/2025	10:15:00 AM	0.5

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/2/2025	10:30:00 AM	0.49
10/2/2025	10:45:00 AM	0.49
10/2/2025	11:00:00 AM	0.49
10/2/2025	11:15:00 AM	0.49
10/2/2025	11:30:00 AM	0.49
10/2/2025	11:45:00 AM	0.49
10/2/2025	12:00:00 PM	0.49
10/2/2025	12:15:00 PM	0.49
10/2/2025	12:30:00 PM	0.49
10/2/2025	12:45:00 PM	0.49
10/2/2025	1:00:00 PM	0.49
10/2/2025	1:15:00 PM	0.49
10/2/2025	1:30:00 PM	0.49
10/2/2025	1:45:00 PM	0.49
10/2/2025	2:00:00 PM	0.49
10/2/2025	2:15:00 PM	0.49
10/2/2025	2:30:00 PM	0.49
10/2/2025	2:45:00 PM	0.49
10/2/2025	3:00:00 PM	0.49
10/2/2025	3:15:00 PM	0.48
10/2/2025	3:30:00 PM	0.48
10/2/2025	3:45:00 PM	0.48
10/2/2025	4:00:00 PM	0.48
10/2/2025	4:15:00 PM	0.48
10/2/2025	4:30:00 PM	0.48
10/2/2025	4:45:00 PM	0.48
10/2/2025	5:00:00 PM	0.48
10/2/2025	5:15:00 PM	0.48
10/2/2025	5:30:00 PM	0.48
10/2/2025	5:45:00 PM	0.48
10/2/2025	6:00:00 PM	0.48
10/2/2025	6:15:00 PM	0.48
10/2/2025	6:30:00 PM	0.48
10/2/2025	6:45:00 PM	0.48
10/2/2025	7:00:00 PM	0.48
10/2/2025	7:15:00 PM	0.48
10/2/2025	7:30:00 PM	0.48
10/2/2025	7:45:00 PM	0.48
10/2/2025	8:00:00 PM	0.48
10/2/2025	8:15:00 PM	0.48
10/2/2025	8:30:00 PM	0.48
10/2/2025	8:45:00 PM	0.48
10/2/2025	9:00:00 PM	0.48
10/2/2025	9:15:00 PM	0.48
10/2/2025	9:30:00 PM	0.48
10/2/2025	9:45:00 PM	0.48

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/2/2025	10:00:00 PM	0.48
10/2/2025	10:15:00 PM	0.48
10/2/2025	10:30:00 PM	0.48
10/2/2025	10:45:00 PM	0.48
10/2/2025	11:00:00 PM	0.48
10/2/2025	11:15:00 PM	0.48
10/2/2025	11:30:00 PM	0.48
10/2/2025	11:45:00 PM	0.48
10/3/2025	12:00:00 AM	0.48
10/3/2025	12:15:00 AM	0.48
10/3/2025	12:30:00 AM	0.48
10/3/2025	12:45:00 AM	0.48
10/3/2025	1:00:00 AM	0.48
10/3/2025	1:15:00 AM	0.48
10/3/2025	1:30:00 AM	0.48
10/3/2025	1:45:00 AM	0.48
10/3/2025	2:00:00 AM	0.48
10/3/2025	2:15:00 AM	0.48
10/3/2025	2:30:00 AM	0.48
10/3/2025	2:45:00 AM	0.48
10/3/2025	3:00:00 AM	0.48
10/3/2025	3:15:00 AM	0.49
10/3/2025	3:30:00 AM	0.49
10/3/2025	3:45:00 AM	0.49
10/3/2025	4:00:00 AM	0.49
10/3/2025	4:15:00 AM	0.49
10/3/2025	4:30:00 AM	0.49
10/3/2025	4:45:00 AM	0.49
10/3/2025	5:00:00 AM	0.49
10/3/2025	5:15:00 AM	0.49
10/3/2025	5:30:00 AM	0.48
10/3/2025	5:45:00 AM	0.49
10/3/2025	6:00:00 AM	0.48
10/3/2025	6:15:00 AM	0.48
10/3/2025	6:30:00 AM	0.48
10/3/2025	6:45:00 AM	0.48
10/3/2025	7:00:00 AM	0.48
10/3/2025	7:15:00 AM	0.48
10/3/2025	7:30:00 AM	0.48
10/3/2025	7:45:00 AM	0.48
10/3/2025	8:00:00 AM	0.48
10/3/2025	8:15:00 AM	0.48
10/3/2025	8:30:00 AM	0.48
10/3/2025	8:45:00 AM	0.48
10/3/2025	9:00:00 AM	0.47
10/3/2025	9:15:00 AM	0.47

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/3/2025	9:30:00 AM	0.47
10/3/2025	9:45:00 AM	0.47
10/3/2025	10:00:00 AM	0.47
10/3/2025	10:15:00 AM	0.47
10/3/2025	10:30:00 AM	0.46
10/3/2025	10:45:00 AM	0.46
10/3/2025	11:00:00 AM	0.46
10/3/2025	11:15:00 AM	0.45
10/3/2025	11:30:00 AM	0.45
10/3/2025	11:45:00 AM	0.45
10/3/2025	12:00:00 PM	0.45
10/3/2025	12:15:00 PM	0.44
10/3/2025	12:30:00 PM	0.44
10/3/2025	12:45:00 PM	0.44
10/3/2025	1:00:00 PM	0.43
10/3/2025	1:15:00 PM	0.43
10/3/2025	1:30:00 PM	0.43
10/3/2025	1:45:00 PM	0.42
10/3/2025	2:00:00 PM	0.42
10/3/2025	2:15:00 PM	0.42
10/3/2025	2:30:00 PM	0.41
10/3/2025	2:45:00 PM	0.41
10/3/2025	3:00:00 PM	0.4
10/3/2025	3:15:00 PM	0.4
10/3/2025	3:30:00 PM	0.4
10/3/2025	3:45:00 PM	0.39
10/3/2025	4:00:00 PM	0.39
10/3/2025	4:15:00 PM	0.39
10/3/2025	4:30:00 PM	0.39
10/3/2025	4:45:00 PM	0.38
10/3/2025	5:00:00 PM	0.38
10/3/2025	5:15:00 PM	0.38
10/3/2025	5:30:00 PM	0.38
10/3/2025	5:45:00 PM	0.38
10/3/2025	6:00:00 PM	0.37
10/3/2025	6:15:00 PM	0.37
10/3/2025	6:30:00 PM	0.37
10/3/2025	6:45:00 PM	0.37
10/3/2025	7:00:00 PM	0.37
10/3/2025	7:15:00 PM	0.37
10/3/2025	7:30:00 PM	0.37
10/3/2025	7:45:00 PM	0.37
10/3/2025	8:00:00 PM	0.37
10/3/2025	8:15:00 PM	0.37
10/3/2025	8:30:00 PM	0.37
10/3/2025	8:45:00 PM	0.37

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/3/2025	9:00:00 PM	0.37
10/3/2025	9:15:00 PM	0.37
10/3/2025	9:30:00 PM	0.37
10/3/2025	9:45:00 PM	0.38
10/3/2025	10:00:00 PM	0.38
10/3/2025	10:15:00 PM	0.38
10/3/2025	10:30:00 PM	0.39
10/3/2025	10:45:00 PM	0.39
10/3/2025	11:00:00 PM	0.39
10/3/2025	11:15:00 PM	0.4
10/3/2025	11:30:00 PM	0.4
10/3/2025	11:45:00 PM	0.41
10/4/2025	12:00:00 AM	0.41
10/4/2025	12:15:00 AM	0.41
10/4/2025	12:30:00 AM	0.41
10/4/2025	12:45:00 AM	0.42
10/4/2025	1:00:00 AM	0.42
10/4/2025	1:15:00 AM	0.42
10/4/2025	1:30:00 AM	0.43
10/4/2025	1:45:00 AM	0.43
10/4/2025	2:00:00 AM	0.43
10/4/2025	2:15:00 AM	0.44
10/4/2025	2:30:00 AM	0.44
10/4/2025	2:45:00 AM	0.44
10/4/2025	3:00:00 AM	0.44
10/4/2025	3:15:00 AM	0.44
10/4/2025	3:30:00 AM	0.45
10/4/2025	3:45:00 AM	0.45
10/4/2025	4:00:00 AM	0.45
10/4/2025	4:15:00 AM	0.45
10/4/2025	4:30:00 AM	0.45
10/4/2025	4:45:00 AM	0.46
10/4/2025	5:00:00 AM	0.46
10/4/2025	5:15:00 AM	0.46
10/4/2025	5:30:00 AM	0.46
10/4/2025	5:45:00 AM	0.47
10/4/2025	6:00:00 AM	0.47
10/4/2025	6:15:00 AM	0.47
10/4/2025	6:30:00 AM	0.47
10/4/2025	6:45:00 AM	0.47
10/4/2025	7:00:00 AM	0.47
10/4/2025	7:15:00 AM	0.47
10/4/2025	7:30:00 AM	0.47
10/4/2025	7:45:00 AM	0.47
10/4/2025	8:00:00 AM	0.47
10/4/2025	8:15:00 AM	0.47

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/4/2025	8:30:00 AM	0.48
10/4/2025	8:45:00 AM	0.48
10/4/2025	9:00:00 AM	0.48
10/4/2025	9:15:00 AM	0.48
10/4/2025	9:30:00 AM	0.48
10/4/2025	9:45:00 AM	0.48
10/4/2025	10:00:00 AM	0.48
10/4/2025	10:15:00 AM	0.48
10/4/2025	10:30:00 AM	0.48
10/4/2025	10:45:00 AM	0.48
10/4/2025	11:00:00 AM	0.48
10/4/2025	11:15:00 AM	0.48
10/4/2025	11:30:00 AM	0.48
10/4/2025	11:45:00 AM	0.48
10/4/2025	12:00:00 PM	0.48
10/4/2025	12:15:00 PM	0.48
10/4/2025	12:30:00 PM	0.48
10/4/2025	12:45:00 PM	0.48
10/4/2025	1:00:00 PM	0.48
10/4/2025	1:15:00 PM	0.48
10/4/2025	1:30:00 PM	0.48
10/4/2025	1:45:00 PM	0.48
10/4/2025	2:00:00 PM	0.48
10/4/2025	2:15:00 PM	0.47
10/4/2025	2:30:00 PM	0.48
10/4/2025	2:45:00 PM	0.47
10/4/2025	3:00:00 PM	0.47
10/4/2025	3:15:00 PM	0.47
10/4/2025	3:30:00 PM	0.47
10/4/2025	3:45:00 PM	0.47
10/4/2025	4:00:00 PM	0.47
10/4/2025	4:15:00 PM	0.47
10/4/2025	4:30:00 PM	0.47
10/4/2025	4:45:00 PM	0.47
10/4/2025	5:00:00 PM	0.47
10/4/2025	5:15:00 PM	0.47
10/4/2025	5:30:00 PM	0.47
10/4/2025	5:45:00 PM	0.47
10/4/2025	6:00:00 PM	0.47
10/4/2025	6:15:00 PM	0.47
10/4/2025	6:30:00 PM	0.47
10/4/2025	6:45:00 PM	0.47
10/4/2025	7:00:00 PM	0.47
10/4/2025	7:15:00 PM	0.47
10/4/2025	7:30:00 PM	0.47
10/4/2025	7:45:00 PM	0.47

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/4/2025	8:00:00 PM	0.47
10/4/2025	8:15:00 PM	0.48
10/4/2025	8:30:00 PM	0.47
10/4/2025	8:45:00 PM	0.47
10/4/2025	9:00:00 PM	0.47
10/4/2025	9:15:00 PM	0.48
10/4/2025	9:30:00 PM	0.48
10/4/2025	9:45:00 PM	0.48
10/4/2025	10:00:00 PM	0.48
10/4/2025	10:15:00 PM	0.48
10/4/2025	10:30:00 PM	0.48
10/4/2025	10:45:00 PM	0.48
10/4/2025	11:00:00 PM	0.48
10/4/2025	11:15:00 PM	0.48
10/4/2025	11:30:00 PM	0.48
10/4/2025	11:45:00 PM	0.48
10/5/2025	12:00:00 AM	0.48
10/5/2025	12:15:00 AM	0.48
10/5/2025	12:30:00 AM	0.48
10/5/2025	12:45:00 AM	0.48
10/5/2025	1:00:00 AM	0.48
10/5/2025	1:15:00 AM	0.48
10/5/2025	1:30:00 AM	0.48
10/5/2025	1:45:00 AM	0.48
10/5/2025	2:00:00 AM	0.48
10/5/2025	2:15:00 AM	0.48
10/5/2025	2:30:00 AM	0.48
10/5/2025	2:45:00 AM	0.48
10/5/2025	3:00:00 AM	0.48
10/5/2025	3:15:00 AM	0.48
10/5/2025	3:30:00 AM	0.48
10/5/2025	3:45:00 AM	0.48
10/5/2025	4:00:00 AM	0.48
10/5/2025	4:15:00 AM	0.48
10/5/2025	4:30:00 AM	0.48
10/5/2025	4:45:00 AM	0.48
10/5/2025	5:00:00 AM	0.48
10/5/2025	5:15:00 AM	0.48
10/5/2025	5:30:00 AM	0.48
10/5/2025	5:45:00 AM	0.48
10/5/2025	6:00:00 AM	0.48
10/5/2025	6:15:00 AM	0.48
10/5/2025	6:30:00 AM	0.48
10/5/2025	6:45:00 AM	0.48
10/5/2025	7:00:00 AM	0.48
10/5/2025	7:15:00 AM	0.48

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/5/2025	7:30:00 AM	0.48
10/5/2025	7:45:00 AM	0.48
10/5/2025	8:00:00 AM	0.48
10/5/2025	8:15:00 AM	0.48
10/5/2025	8:30:00 AM	0.48
10/5/2025	8:45:00 AM	0.48
10/5/2025	9:00:00 AM	0.48
10/5/2025	9:15:00 AM	0.48
10/5/2025	9:30:00 AM	0.48
10/5/2025	9:45:00 AM	0.48
10/5/2025	10:00:00 AM	0.48
10/5/2025	10:15:00 AM	0.48
10/5/2025	10:30:00 AM	0.47
10/5/2025	10:45:00 AM	0.47
10/5/2025	11:00:00 AM	0.47
10/5/2025	11:15:00 AM	0.47
10/5/2025	11:30:00 AM	0.47
10/5/2025	11:45:00 AM	0.47
10/5/2025	12:00:00 PM	0.47
10/5/2025	12:15:00 PM	0.47
10/5/2025	12:30:00 PM	0.47
10/5/2025	12:45:00 PM	0.47
10/5/2025	1:00:00 PM	0.47
10/5/2025	1:15:00 PM	0.47
10/5/2025	1:30:00 PM	0.47
10/5/2025	1:45:00 PM	0.47
10/5/2025	2:00:00 PM	0.47
10/5/2025	2:15:00 PM	0.47
10/5/2025	2:30:00 PM	0.47
10/5/2025	2:45:00 PM	0.47
10/5/2025	3:00:00 PM	0.47
10/5/2025	3:15:00 PM	0.47
10/5/2025	3:30:00 PM	0.47
10/5/2025	3:45:00 PM	0.47
10/5/2025	4:00:00 PM	0.47
10/5/2025	4:15:00 PM	0.47
10/5/2025	4:30:00 PM	0.47
10/5/2025	4:45:00 PM	0.47
10/5/2025	5:00:00 PM	0.47
10/5/2025	5:15:00 PM	0.47
10/5/2025	5:30:00 PM	0.47
10/5/2025	5:45:00 PM	0.47
10/5/2025	6:00:00 PM	0.47
10/5/2025	6:15:00 PM	0.47
10/5/2025	6:30:00 PM	0.47
10/5/2025	6:45:00 PM	0.47

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/5/2025	7:00:00 PM	0.47
10/5/2025	7:15:00 PM	0.47
10/5/2025	7:30:00 PM	0.47
10/5/2025	7:45:00 PM	0.47
10/5/2025	8:00:00 PM	0.47
10/5/2025	8:15:00 PM	0.47
10/5/2025	8:30:00 PM	0.47
10/5/2025	8:45:00 PM	0.47
10/5/2025	9:00:00 PM	0.47
10/5/2025	9:15:00 PM	0.47
10/5/2025	9:30:00 PM	0.47
10/5/2025	9:45:00 PM	0.47
10/5/2025	10:00:00 PM	0.47
10/5/2025	10:15:00 PM	0.47
10/5/2025	10:30:00 PM	0.47
10/5/2025	10:45:00 PM	0.47
10/5/2025	11:00:00 PM	0.47
10/5/2025	11:15:00 PM	0.47
10/5/2025	11:30:00 PM	0.47
10/5/2025	11:45:00 PM	0.47
10/6/2025	12:00:00 AM	0.47
10/6/2025	12:15:00 AM	0.47
10/6/2025	12:30:00 AM	0.47
10/6/2025	12:45:00 AM	0.47
10/6/2025	1:00:00 AM	0.47
10/6/2025	1:15:00 AM	0.47
10/6/2025	1:30:00 AM	0.47
10/6/2025	1:45:00 AM	0.47
10/6/2025	2:00:00 AM	0.47
10/6/2025	2:15:00 AM	0.47
10/6/2025	2:30:00 AM	0.47
10/6/2025	2:45:00 AM	0.47
10/6/2025	3:00:00 AM	0.47
10/6/2025	3:15:00 AM	0.47
10/6/2025	3:30:00 AM	0.47
10/6/2025	3:45:00 AM	0.47
10/6/2025	4:00:00 AM	0.47
10/6/2025	4:15:00 AM	0.47
10/6/2025	4:30:00 AM	0.46
10/6/2025	4:45:00 AM	0.46
10/6/2025	5:00:00 AM	0.46
10/6/2025	5:15:00 AM	0.46
10/6/2025	5:30:00 AM	0.46
10/6/2025	5:45:00 AM	0.46
10/6/2025	6:00:00 AM	0.46
10/6/2025	6:15:00 AM	0.46

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/6/2025	6:30:00 AM	0.46
10/6/2025	6:45:00 AM	0.46
10/6/2025	7:00:00 AM	0.46
10/6/2025	7:15:00 AM	0.46
10/6/2025	7:30:00 AM	0.46
10/6/2025	7:45:00 AM	0.45
10/6/2025	8:00:00 AM	0.45
10/6/2025	8:15:00 AM	0.45
10/6/2025	8:30:00 AM	0.45
10/6/2025	8:45:00 AM	0.45
10/6/2025	9:00:00 AM	0.45
10/6/2025	9:15:00 AM	0.45
10/6/2025	9:30:00 AM	0.44
10/6/2025	9:45:00 AM	0.44
10/6/2025	10:00:00 AM	0.44
10/6/2025	10:15:00 AM	0.43
10/6/2025	10:30:00 AM	0.43
10/6/2025	10:45:00 AM	0.43
10/6/2025	11:00:00 AM	0.43
10/6/2025	11:15:00 AM	0.43
10/6/2025	11:30:00 AM	0.43
10/6/2025	11:45:00 AM	0.43
10/6/2025	12:00:00 PM	0.43
10/6/2025	12:15:00 PM	0.43
10/6/2025	12:30:00 PM	0.43
10/6/2025	12:45:00 PM	0.43
10/6/2025	1:00:00 PM	0.43
10/6/2025	1:15:00 PM	0.43
10/6/2025	1:30:00 PM	0.43
10/6/2025	1:45:00 PM	0.43
10/6/2025	2:00:00 PM	0.43
10/6/2025	2:15:00 PM	0.43
10/6/2025	2:30:00 PM	0.43
10/6/2025	2:45:00 PM	0.43
10/6/2025	3:00:00 PM	0.43
10/6/2025	3:15:00 PM	0.43
10/6/2025	3:30:00 PM	0.43
10/6/2025	3:45:00 PM	0.43
10/6/2025	4:00:00 PM	0.43
10/6/2025	4:15:00 PM	0.43
10/6/2025	4:30:00 PM	0.43
10/6/2025	4:45:00 PM	0.43
10/6/2025	5:00:00 PM	0.43
10/6/2025	5:15:00 PM	0.43
10/6/2025	5:30:00 PM	0.43
10/6/2025	5:45:00 PM	0.43

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/6/2025	6:00:00 PM	0.43
10/6/2025	6:15:00 PM	0.43
10/6/2025	6:30:00 PM	0.43
10/6/2025	6:45:00 PM	0.43
10/6/2025	7:00:00 PM	0.43
10/6/2025	7:15:00 PM	0.44
10/6/2025	7:30:00 PM	0.44
10/6/2025	7:45:00 PM	0.44
10/6/2025	8:00:00 PM	0.44
10/6/2025	8:15:00 PM	0.44
10/6/2025	8:30:00 PM	0.44
10/6/2025	8:45:00 PM	0.44
10/6/2025	9:00:00 PM	0.44
10/6/2025	9:15:00 PM	0.44
10/6/2025	9:30:00 PM	0.44
10/6/2025	9:45:00 PM	0.44
10/6/2025	10:00:00 PM	0.44
10/6/2025	10:15:00 PM	0.44
10/6/2025	10:30:00 PM	0.44
10/6/2025	10:45:00 PM	0.44
10/6/2025	11:00:00 PM	0.44
10/6/2025	11:15:00 PM	0.44
10/6/2025	11:30:00 PM	0.44
10/6/2025	11:45:00 PM	0.44
10/7/2025	12:00:00 AM	0.44
10/7/2025	12:15:00 AM	0.44
10/7/2025	12:30:00 AM	0.44
10/7/2025	12:45:00 AM	0.44
10/7/2025	1:00:00 AM	0.44
10/7/2025	1:15:00 AM	0.44
10/7/2025	1:30:00 AM	0.44
10/7/2025	1:45:00 AM	0.44
10/7/2025	2:00:00 AM	0.44
10/7/2025	2:15:00 AM	0.45
10/7/2025	2:30:00 AM	0.45
10/7/2025	2:45:00 AM	0.45
10/7/2025	3:00:00 AM	0.45
10/7/2025	3:15:00 AM	0.45
10/7/2025	3:30:00 AM	0.45
10/7/2025	3:45:00 AM	0.45
10/7/2025	4:00:00 AM	0.45
10/7/2025	4:15:00 AM	0.45
10/7/2025	4:30:00 AM	0.45
10/7/2025	4:45:00 AM	0.45
10/7/2025	5:00:00 AM	0.45
10/7/2025	5:15:00 AM	0.45

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/7/2025	5:30:00 AM	0.45
10/7/2025	5:45:00 AM	0.45
10/7/2025	6:00:00 AM	0.45
10/7/2025	6:15:00 AM	0.45
10/7/2025	6:30:00 AM	0.45
10/7/2025	6:45:00 AM	0.45
10/7/2025	7:00:00 AM	0.45
10/7/2025	7:15:00 AM	0.45
10/7/2025	7:30:00 AM	0.45
10/7/2025	7:45:00 AM	0.45
10/7/2025	8:00:00 AM	0.45
10/7/2025	8:15:00 AM	0.45
10/7/2025	8:30:00 AM	0.45
10/7/2025	8:45:00 AM	0.45
10/7/2025	9:00:00 AM	0.45
10/7/2025	9:15:00 AM	0.45
10/7/2025	9:30:00 AM	0.45
10/7/2025	9:45:00 AM	0.45
10/7/2025	10:00:00 AM	0.45
10/7/2025	10:15:00 AM	0.45
10/7/2025	10:30:00 AM	0.45
10/7/2025	10:45:00 AM	0.44
10/7/2025	11:00:00 AM	0.44
10/7/2025	11:15:00 AM	0.44
10/7/2025	11:30:00 AM	0.44
10/7/2025	11:45:00 AM	0.44
10/7/2025	12:00:00 PM	0.44
10/7/2025	12:15:00 PM	0.44
10/7/2025	12:30:00 PM	0.44
10/7/2025	12:45:00 PM	0.44
10/7/2025	1:00:00 PM	0.44
10/7/2025	1:15:00 PM	0.44
10/7/2025	1:30:00 PM	0.44
10/7/2025	1:45:00 PM	0.44
10/7/2025	2:00:00 PM	0.45
10/7/2025	2:15:00 PM	0.45
10/7/2025	2:30:00 PM	0.45
10/7/2025	2:45:00 PM	0.45
10/7/2025	3:00:00 PM	0.45
10/7/2025	3:15:00 PM	0.44
10/7/2025	3:30:00 PM	0.45
10/7/2025	3:45:00 PM	0.45
10/7/2025	4:00:00 PM	0.45
10/7/2025	4:15:00 PM	0.45
10/7/2025	4:30:00 PM	0.45
10/7/2025	4:45:00 PM	0.45

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/7/2025	5:00:00 PM	0.45
10/7/2025	5:15:00 PM	0.45
10/7/2025	5:30:00 PM	0.45
10/7/2025	5:45:00 PM	0.45
10/7/2025	6:00:00 PM	0.45
10/7/2025	6:15:00 PM	0.45
10/7/2025	6:30:00 PM	0.45
10/7/2025	6:45:00 PM	0.45
10/7/2025	7:00:00 PM	0.45
10/7/2025	7:15:00 PM	0.45
10/7/2025	7:30:00 PM	0.45
10/7/2025	7:45:00 PM	0.45
10/7/2025	8:00:00 PM	0.45
10/7/2025	8:15:00 PM	0.45
10/7/2025	8:30:00 PM	0.45
10/7/2025	8:45:00 PM	0.45
10/7/2025	9:00:00 PM	0.45
10/7/2025	9:15:00 PM	0.45
10/7/2025	9:30:00 PM	0.45
10/7/2025	9:45:00 PM	0.45
10/7/2025	10:00:00 PM	0.45
10/7/2025	10:15:00 PM	0.45
10/7/2025	10:30:00 PM	0.45
10/7/2025	10:45:00 PM	0.45
10/7/2025	11:00:00 PM	0.45
10/7/2025	11:15:00 PM	0.45
10/7/2025	11:30:00 PM	0.45
10/7/2025	11:45:00 PM	0.45
10/8/2025	12:00:00 AM	0.45
10/8/2025	12:15:00 AM	0.45
10/8/2025	12:30:00 AM	0.45
10/8/2025	12:45:00 AM	0.45
10/8/2025	1:00:00 AM	0.45
10/8/2025	1:15:00 AM	0.45
10/8/2025	1:30:00 AM	0.45
10/8/2025	1:45:00 AM	0.45
10/8/2025	2:00:00 AM	0.45
10/8/2025	2:15:00 AM	0.45
10/8/2025	2:30:00 AM	0.46
10/8/2025	2:45:00 AM	0.46
10/8/2025	3:00:00 AM	0.46
10/8/2025	3:15:00 AM	0.46
10/8/2025	3:30:00 AM	0.46
10/8/2025	3:45:00 AM	0.46
10/8/2025	4:00:00 AM	0.46
10/8/2025	4:15:00 AM	0.46

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/8/2025	4:30:00 AM	0.46
10/8/2025	4:45:00 AM	0.46
10/8/2025	5:00:00 AM	0.46
10/8/2025	5:15:00 AM	0.46
10/8/2025	5:30:00 AM	0.46
10/8/2025	5:45:00 AM	0.46
10/8/2025	6:00:00 AM	0.46
10/8/2025	6:15:00 AM	0.46
10/8/2025	6:30:00 AM	0.46
10/8/2025	6:45:00 AM	0.46
10/8/2025	7:00:00 AM	0.46
10/8/2025	7:15:00 AM	0.46
10/8/2025	7:30:00 AM	0.46
10/8/2025	7:45:00 AM	.
10/8/2025	8:00:00 AM	.
10/8/2025	8:15:00 AM	.
10/8/2025	8:30:00 AM	.
10/8/2025	8:45:00 AM	0.46
10/8/2025	9:00:00 AM	0.46
10/8/2025	9:15:00 AM	0.46
10/8/2025	9:30:00 AM	0.46
10/8/2025	9:45:00 AM	0.46
10/8/2025	10:00:00 AM	0.46
10/8/2025	10:15:00 AM	0.46
10/8/2025	10:30:00 AM	0.46
10/8/2025	10:45:00 AM	0.46
10/8/2025	11:00:00 AM	0.46
10/8/2025	11:15:00 AM	0.46
10/8/2025	11:30:00 AM	0.46
10/8/2025	11:45:00 AM	0.46
10/8/2025	12:00:00 PM	0.47
10/8/2025	12:15:00 PM	0.47
10/8/2025	12:30:00 PM	0.47
10/8/2025	12:45:00 PM	0.47
10/8/2025	1:00:00 PM	0.47
10/8/2025	1:15:00 PM	0.47
10/8/2025	1:30:00 PM	0.47
10/8/2025	1:45:00 PM	0.47
10/8/2025	2:00:00 PM	0.48
10/8/2025	2:15:00 PM	0.48
10/8/2025	2:30:00 PM	0.48
10/8/2025	2:45:00 PM	0.48
10/8/2025	3:00:00 PM	0.48
10/8/2025	3:15:00 PM	0.48
10/8/2025	3:30:00 PM	0.49
10/8/2025	3:45:00 PM	0.49

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/8/2025	4:00:00 PM	0.49
10/8/2025	4:15:00 PM	0.49
10/8/2025	4:30:00 PM	0.49
10/8/2025	4:45:00 PM	0.49
10/8/2025	5:00:00 PM	0.49
10/8/2025	5:15:00 PM	0.49
10/8/2025	5:30:00 PM	0.49
10/8/2025	5:45:00 PM	0.49
10/8/2025	6:00:00 PM	0.5
10/8/2025	6:15:00 PM	0.5
10/8/2025	6:30:00 PM	0.5
10/8/2025	6:45:00 PM	0.5
10/8/2025	7:00:00 PM	0.5
10/8/2025	7:15:00 PM	0.5
10/8/2025	7:30:00 PM	0.5
10/8/2025	7:45:00 PM	0.51
10/8/2025	8:00:00 PM	0.51
10/8/2025	8:15:00 PM	0.51
10/8/2025	8:30:00 PM	0.51
10/8/2025	8:45:00 PM	0.51
10/8/2025	9:00:00 PM	0.51
10/8/2025	9:15:00 PM	0.51
10/8/2025	9:30:00 PM	0.51
10/8/2025	9:45:00 PM	0.51
10/8/2025	10:00:00 PM	0.51
10/8/2025	10:15:00 PM	0.52
10/8/2025	10:30:00 PM	0.52
10/8/2025	10:45:00 PM	0.52
10/8/2025	11:00:00 PM	0.52
10/8/2025	11:15:00 PM	0.52
10/8/2025	11:30:00 PM	0.52
10/8/2025	11:45:00 PM	0.52
10/9/2025	12:00:00 AM	0.52
10/9/2025	12:15:00 AM	0.52
10/9/2025	12:30:00 AM	0.52
10/9/2025	12:45:00 AM	0.52
10/9/2025	1:00:00 AM	0.52
10/9/2025	1:15:00 AM	0.52
10/9/2025	1:30:00 AM	0.53
10/9/2025	1:45:00 AM	0.53
10/9/2025	2:00:00 AM	0.53
10/9/2025	2:15:00 AM	0.53
10/9/2025	2:30:00 AM	0.53
10/9/2025	2:45:00 AM	0.53
10/9/2025	3:00:00 AM	0.53
10/9/2025	3:15:00 AM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/9/2025	3:30:00 AM	0.53
10/9/2025	3:45:00 AM	0.53
10/9/2025	4:00:00 AM	0.53
10/9/2025	4:15:00 AM	0.53
10/9/2025	4:30:00 AM	0.53
10/9/2025	4:45:00 AM	0.53
10/9/2025	5:00:00 AM	0.53
10/9/2025	5:15:00 AM	0.53
10/9/2025	5:30:00 AM	0.53
10/9/2025	5:45:00 AM	0.53
10/9/2025	6:00:00 AM	0.53
10/9/2025	6:15:00 AM	0.54
10/9/2025	6:30:00 AM	0.54
10/9/2025	6:45:00 AM	0.54
10/9/2025	7:00:00 AM	0.54
10/9/2025	7:15:00 AM	0.54
10/9/2025	7:30:00 AM	0.54
10/9/2025	7:45:00 AM	0.54
10/9/2025	8:00:00 AM	0.54
10/9/2025	8:15:00 AM	0.54
10/9/2025	8:30:00 AM	0.54
10/9/2025	8:45:00 AM	0.54
10/9/2025	9:00:00 AM	0.54
10/9/2025	9:15:00 AM	0.54
10/9/2025	9:30:00 AM	0.54
10/9/2025	9:45:00 AM	0.54
10/9/2025	10:00:00 AM	0.54
10/9/2025	10:15:00 AM	0.54
10/9/2025	10:30:00 AM	0.54
10/9/2025	10:45:00 AM	0.54
10/9/2025	11:00:00 AM	0.54
10/9/2025	11:15:00 AM	0.54
10/9/2025	11:30:00 AM	0.54
10/9/2025	11:45:00 AM	0.54
10/9/2025	12:00:00 PM	0.54
10/9/2025	12:15:00 PM	0.54
10/9/2025	12:30:00 PM	0.54
10/9/2025	12:45:00 PM	0.54
10/9/2025	1:00:00 PM	0.54
10/9/2025	1:15:00 PM	0.54
10/9/2025	1:30:00 PM	0.54
10/9/2025	1:45:00 PM	0.54
10/9/2025	2:00:00 PM	0.54
10/9/2025	2:15:00 PM	0.54
10/9/2025	2:30:00 PM	0.53
10/9/2025	2:45:00 PM	0.54

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/9/2025	3:00:00 PM	0.53
10/9/2025	3:15:00 PM	0.53
10/9/2025	3:30:00 PM	0.53
10/9/2025	3:45:00 PM	0.53
10/9/2025	4:00:00 PM	0.53
10/9/2025	4:15:00 PM	0.53
10/9/2025	4:30:00 PM	0.53
10/9/2025	4:45:00 PM	0.53
10/9/2025	5:00:00 PM	0.53
10/9/2025	5:15:00 PM	0.53
10/9/2025	5:30:00 PM	0.53
10/9/2025	5:45:00 PM	0.53
10/9/2025	6:00:00 PM	0.53
10/9/2025	6:15:00 PM	0.53
10/9/2025	6:30:00 PM	0.53
10/9/2025	6:45:00 PM	0.53
10/9/2025	7:00:00 PM	0.53
10/9/2025	7:15:00 PM	0.53
10/9/2025	7:30:00 PM	0.53
10/9/2025	7:45:00 PM	0.53
10/9/2025	8:00:00 PM	0.53
10/9/2025	8:15:00 PM	0.53
10/9/2025	8:30:00 PM	0.53
10/9/2025	8:45:00 PM	0.53
10/9/2025	9:00:00 PM	0.53
10/9/2025	9:15:00 PM	0.53
10/9/2025	9:30:00 PM	0.53
10/9/2025	9:45:00 PM	0.53
10/9/2025	10:00:00 PM	0.53
10/9/2025	10:15:00 PM	0.53
10/9/2025	10:30:00 PM	0.53
10/9/2025	10:45:00 PM	0.53
10/9/2025	11:00:00 PM	0.53
10/9/2025	11:15:00 PM	0.53
10/9/2025	11:30:00 PM	0.53
10/9/2025	11:45:00 PM	0.53
10/10/2025	12:00:00 AM	0.53
10/10/2025	12:15:00 AM	0.53
10/10/2025	12:30:00 AM	0.53
10/10/2025	12:45:00 AM	0.53
10/10/2025	1:00:00 AM	0.53
10/10/2025	1:15:00 AM	0.53
10/10/2025	1:30:00 AM	0.53
10/10/2025	1:45:00 AM	0.53
10/10/2025	2:00:00 AM	0.53
10/10/2025	2:15:00 AM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/10/2025	2:30:00 AM	0.53
10/10/2025	2:45:00 AM	0.53
10/10/2025	3:00:00 AM	0.53
10/10/2025	3:15:00 AM	0.53
10/10/2025	3:30:00 AM	0.53
10/10/2025	3:45:00 AM	0.53
10/10/2025	4:00:00 AM	0.53
10/10/2025	4:15:00 AM	0.53
10/10/2025	4:30:00 AM	0.53
10/10/2025	4:45:00 AM	0.53
10/10/2025	5:00:00 AM	0.53
10/10/2025	5:15:00 AM	0.53
10/10/2025	5:30:00 AM	0.53
10/10/2025	5:45:00 AM	0.53
10/10/2025	6:00:00 AM	0.53
10/10/2025	6:15:00 AM	0.53
10/10/2025	6:30:00 AM	0.53
10/10/2025	6:45:00 AM	0.53
10/10/2025	7:00:00 AM	0.53
10/10/2025	7:15:00 AM	0.53
10/10/2025	7:30:00 AM	0.53
10/10/2025	7:45:00 AM	0.53
10/10/2025	8:00:00 AM	0.53
10/10/2025	8:15:00 AM	0.53
10/10/2025	8:30:00 AM	0.53
10/10/2025	8:45:00 AM	0.53
10/10/2025	9:00:00 AM	0.53
10/10/2025	9:15:00 AM	0.53
10/10/2025	9:30:00 AM	0.53
10/10/2025	9:45:00 AM	0.53
10/10/2025	10:00:00 AM	0.53
10/10/2025	10:15:00 AM	0.53
10/10/2025	10:30:00 AM	0.53
10/10/2025	10:45:00 AM	0.53
10/10/2025	11:00:00 AM	0.53
10/10/2025	11:15:00 AM	0.53
10/10/2025	11:30:00 AM	0.53
10/10/2025	11:45:00 AM	0.53
10/10/2025	12:00:00 PM	0.53
10/10/2025	12:15:00 PM	0.53
10/10/2025	12:30:00 PM	0.53
10/10/2025	12:45:00 PM	0.53
10/10/2025	1:00:00 PM	0.53
10/10/2025	1:15:00 PM	0.53
10/10/2025	1:30:00 PM	0.53
10/10/2025	1:45:00 PM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/10/2025	2:00:00 PM	0.53
10/10/2025	2:15:00 PM	0.53
10/10/2025	2:30:00 PM	0.52
10/10/2025	2:45:00 PM	0.52
10/10/2025	3:00:00 PM	0.52
10/10/2025	3:15:00 PM	0.52
10/10/2025	3:30:00 PM	0.52
10/10/2025	3:45:00 PM	0.52
10/10/2025	4:00:00 PM	0.52
10/10/2025	4:15:00 PM	0.52
10/10/2025	4:30:00 PM	0.52
10/10/2025	4:45:00 PM	0.52
10/10/2025	5:00:00 PM	0.52
10/10/2025	5:15:00 PM	0.52
10/10/2025	5:30:00 PM	0.52
10/10/2025	5:45:00 PM	0.52
10/10/2025	6:00:00 PM	0.52
10/10/2025	6:15:00 PM	0.52
10/10/2025	6:30:00 PM	0.52
10/10/2025	6:45:00 PM	0.52
10/10/2025	7:00:00 PM	0.52
10/10/2025	7:15:00 PM	0.52
10/10/2025	7:30:00 PM	0.52
10/10/2025	7:45:00 PM	0.52
10/10/2025	8:00:00 PM	0.52
10/10/2025	8:15:00 PM	0.52
10/10/2025	8:30:00 PM	0.52
10/10/2025	8:45:00 PM	0.52
10/10/2025	9:00:00 PM	0.52
10/10/2025	9:15:00 PM	0.52
10/10/2025	9:30:00 PM	0.52
10/10/2025	9:45:00 PM	0.52
10/10/2025	10:00:00 PM	0.52
10/10/2025	10:15:00 PM	0.52
10/10/2025	10:30:00 PM	0.52
10/10/2025	10:45:00 PM	0.52
10/10/2025	11:00:00 PM	0.52
10/10/2025	11:15:00 PM	0.52
10/10/2025	11:30:00 PM	0.52
10/10/2025	11:45:00 PM	0.52
10/11/2025	12:00:00 AM	0.52
10/11/2025	12:15:00 AM	0.52
10/11/2025	12:30:00 AM	0.52
10/11/2025	12:45:00 AM	0.52
10/11/2025	1:00:00 AM	0.52
10/11/2025	1:15:00 AM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/11/2025	1:30:00 AM	0.52
10/11/2025	1:45:00 AM	0.52
10/11/2025	2:00:00 AM	0.52
10/11/2025	2:15:00 AM	0.52
10/11/2025	2:30:00 AM	0.52
10/11/2025	2:45:00 AM	0.52
10/11/2025	3:00:00 AM	0.52
10/11/2025	3:15:00 AM	0.52
10/11/2025	3:30:00 AM	0.52
10/11/2025	3:45:00 AM	0.52
10/11/2025	4:00:00 AM	0.52
10/11/2025	4:15:00 AM	0.52
10/11/2025	4:30:00 AM	0.52
10/11/2025	4:45:00 AM	0.52
10/11/2025	5:00:00 AM	0.52
10/11/2025	5:15:00 AM	0.52
10/11/2025	5:30:00 AM	0.52
10/11/2025	5:45:00 AM	0.52
10/11/2025	6:00:00 AM	0.52
10/11/2025	6:15:00 AM	0.52
10/11/2025	6:30:00 AM	0.52
10/11/2025	6:45:00 AM	0.52
10/11/2025	7:00:00 AM	0.52
10/11/2025	7:15:00 AM	0.53
10/11/2025	7:30:00 AM	0.53
10/11/2025	7:45:00 AM	0.53
10/11/2025	8:00:00 AM	0.53
10/11/2025	8:15:00 AM	0.53
10/11/2025	8:30:00 AM	0.53
10/11/2025	8:45:00 AM	0.53
10/11/2025	9:00:00 AM	0.53
10/11/2025	9:15:00 AM	0.53
10/11/2025	9:30:00 AM	0.53
10/11/2025	9:45:00 AM	0.53
10/11/2025	10:00:00 AM	0.53
10/11/2025	10:15:00 AM	0.53
10/11/2025	10:30:00 AM	0.53
10/11/2025	10:45:00 AM	0.53
10/11/2025	11:00:00 AM	0.53
10/11/2025	11:15:00 AM	0.53
10/11/2025	11:30:00 AM	0.53
10/11/2025	11:45:00 AM	0.53
10/11/2025	12:00:00 PM	0.53
10/11/2025	12:15:00 PM	0.53
10/11/2025	12:30:00 PM	0.53
10/11/2025	12:45:00 PM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/11/2025	1:00:00 PM	0.52
10/11/2025	1:15:00 PM	0.52
10/11/2025	1:30:00 PM	0.52
10/11/2025	1:45:00 PM	0.52
10/11/2025	2:00:00 PM	0.52
10/11/2025	2:15:00 PM	0.52
10/11/2025	2:30:00 PM	0.52
10/11/2025	2:45:00 PM	0.52
10/11/2025	3:00:00 PM	0.52
10/11/2025	3:15:00 PM	0.52
10/11/2025	3:30:00 PM	0.52
10/11/2025	3:45:00 PM	0.52
10/11/2025	4:00:00 PM	0.52
10/11/2025	4:15:00 PM	0.52
10/11/2025	4:30:00 PM	0.52
10/11/2025	4:45:00 PM	0.52
10/11/2025	5:00:00 PM	0.52
10/11/2025	5:15:00 PM	0.52
10/11/2025	5:30:00 PM	0.52
10/11/2025	5:45:00 PM	0.52
10/11/2025	6:00:00 PM	0.52
10/11/2025	6:15:00 PM	0.52
10/11/2025	6:30:00 PM	0.52
10/11/2025	6:45:00 PM	0.52
10/11/2025	7:00:00 PM	0.52
10/11/2025	7:15:00 PM	0.52
10/11/2025	7:30:00 PM	0.52
10/11/2025	7:45:00 PM	0.52
10/11/2025	8:00:00 PM	0.53
10/11/2025	8:15:00 PM	0.53
10/11/2025	8:30:00 PM	0.53
10/11/2025	8:45:00 PM	0.53
10/11/2025	9:00:00 PM	0.53
10/11/2025	9:15:00 PM	0.53
10/11/2025	9:30:00 PM	0.53
10/11/2025	9:45:00 PM	0.53
10/11/2025	10:00:00 PM	0.53
10/11/2025	10:15:00 PM	0.53
10/11/2025	10:30:00 PM	0.53
10/11/2025	10:45:00 PM	0.53
10/11/2025	11:00:00 PM	0.53
10/11/2025	11:15:00 PM	0.53
10/11/2025	11:30:00 PM	0.53
10/11/2025	11:45:00 PM	0.53
10/12/2025	12:00:00 AM	0.53
10/12/2025	12:15:00 AM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/12/2025	12:30:00 AM	0.53
10/12/2025	12:45:00 AM	0.53
10/12/2025	1:00:00 AM	0.53
10/12/2025	1:15:00 AM	0.53
10/12/2025	1:30:00 AM	0.53
10/12/2025	1:45:00 AM	0.53
10/12/2025	2:00:00 AM	0.53
10/12/2025	2:15:00 AM	0.53
10/12/2025	2:30:00 AM	0.53
10/12/2025	2:45:00 AM	0.53
10/12/2025	3:00:00 AM	0.53
10/12/2025	3:15:00 AM	0.53
10/12/2025	3:30:00 AM	0.53
10/12/2025	3:45:00 AM	0.53
10/12/2025	4:00:00 AM	0.53
10/12/2025	4:15:00 AM	0.53
10/12/2025	4:30:00 AM	0.53
10/12/2025	4:45:00 AM	0.53
10/12/2025	5:00:00 AM	0.53
10/12/2025	5:15:00 AM	0.53
10/12/2025	5:30:00 AM	0.53
10/12/2025	5:45:00 AM	0.53
10/12/2025	6:00:00 AM	0.53
10/12/2025	6:15:00 AM	0.53
10/12/2025	6:30:00 AM	0.53
10/12/2025	6:45:00 AM	0.53
10/12/2025	7:00:00 AM	0.53
10/12/2025	7:15:00 AM	0.53
10/12/2025	7:30:00 AM	0.54
10/12/2025	7:45:00 AM	0.54
10/12/2025	8:00:00 AM	0.54
10/12/2025	8:15:00 AM	0.54
10/12/2025	8:30:00 AM	0.54
10/12/2025	8:45:00 AM	0.54
10/12/2025	9:00:00 AM	0.54
10/12/2025	9:15:00 AM	0.54
10/12/2025	9:30:00 AM	0.54
10/12/2025	9:45:00 AM	0.54
10/12/2025	10:00:00 AM	0.54
10/12/2025	10:15:00 AM	0.54
10/12/2025	10:30:00 AM	0.54
10/12/2025	10:45:00 AM	0.54
10/12/2025	11:00:00 AM	0.54
10/12/2025	11:15:00 AM	0.54
10/12/2025	11:30:00 AM	0.54
10/12/2025	11:45:00 AM	0.54

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/12/2025	12:00:00 PM	0.54
10/12/2025	12:15:00 PM	0.54
10/12/2025	12:30:00 PM	0.54
10/12/2025	12:45:00 PM	0.54
10/12/2025	1:00:00 PM	0.54
10/12/2025	1:15:00 PM	0.54
10/12/2025	1:30:00 PM	0.54
10/12/2025	1:45:00 PM	0.54
10/12/2025	2:00:00 PM	0.54
10/12/2025	2:15:00 PM	0.54
10/12/2025	2:30:00 PM	0.54
10/12/2025	2:45:00 PM	0.54
10/12/2025	3:00:00 PM	0.54
10/12/2025	3:15:00 PM	0.54
10/12/2025	3:30:00 PM	0.54
10/12/2025	3:45:00 PM	0.54
10/12/2025	4:00:00 PM	0.54
10/12/2025	4:15:00 PM	0.54
10/12/2025	4:30:00 PM	0.54
10/12/2025	4:45:00 PM	0.54
10/12/2025	5:00:00 PM	0.54
10/12/2025	5:15:00 PM	0.54
10/12/2025	5:30:00 PM	0.54
10/12/2025	5:45:00 PM	0.54
10/12/2025	6:00:00 PM	0.54
10/12/2025	6:15:00 PM	0.54
10/12/2025	6:30:00 PM	0.54
10/12/2025	6:45:00 PM	0.54
10/12/2025	7:00:00 PM	0.54
10/12/2025	7:15:00 PM	0.54
10/12/2025	7:30:00 PM	0.54
10/12/2025	7:45:00 PM	0.54
10/12/2025	8:00:00 PM	0.54
10/12/2025	8:15:00 PM	0.54
10/12/2025	8:30:00 PM	0.54
10/12/2025	8:45:00 PM	0.54
10/12/2025	9:00:00 PM	0.54
10/12/2025	9:15:00 PM	0.54
10/12/2025	9:30:00 PM	0.54
10/12/2025	9:45:00 PM	0.54
10/12/2025	10:00:00 PM	0.54
10/12/2025	10:15:00 PM	0.54
10/12/2025	10:30:00 PM	0.54
10/12/2025	10:45:00 PM	0.54
10/12/2025	11:00:00 PM	0.54
10/12/2025	11:15:00 PM	0.54

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/12/2025	11:30:00 PM	0.54
10/12/2025	11:45:00 PM	0.54
10/13/2025	12:00:00 AM	0.54
10/13/2025	12:15:00 AM	0.54
10/13/2025	12:30:00 AM	0.54
10/13/2025	12:45:00 AM	0.54
10/13/2025	1:00:00 AM	0.54
10/13/2025	1:15:00 AM	0.54
10/13/2025	1:30:00 AM	0.54
10/13/2025	1:45:00 AM	0.54
10/13/2025	2:00:00 AM	0.54
10/13/2025	2:15:00 AM	0.54
10/13/2025	2:30:00 AM	0.54
10/13/2025	2:45:00 AM	0.54
10/13/2025	3:00:00 AM	0.54
10/13/2025	3:15:00 AM	0.54
10/13/2025	3:30:00 AM	0.54
10/13/2025	3:45:00 AM	0.54
10/13/2025	4:00:00 AM	0.54
10/13/2025	4:15:00 AM	0.54
10/13/2025	4:30:00 AM	0.54
10/13/2025	4:45:00 AM	0.54
10/13/2025	5:00:00 AM	0.54
10/13/2025	5:15:00 AM	0.54
10/13/2025	5:30:00 AM	0.54
10/13/2025	5:45:00 AM	0.54
10/13/2025	6:00:00 AM	0.54
10/13/2025	6:15:00 AM	0.54
10/13/2025	6:30:00 AM	0.54
10/13/2025	6:45:00 AM	0.54
10/13/2025	7:00:00 AM	0.54
10/13/2025	7:15:00 AM	0.54
10/13/2025	7:30:00 AM	0.54
10/13/2025	7:45:00 AM	0.54
10/13/2025	8:00:00 AM	0.54
10/13/2025	8:15:00 AM	0.54
10/13/2025	8:30:00 AM	0.54
10/13/2025	8:45:00 AM	0.54
10/13/2025	9:00:00 AM	0.54
10/13/2025	9:15:00 AM	0.55
10/13/2025	9:30:00 AM	0.55
10/13/2025	9:45:00 AM	0.55
10/13/2025	10:00:00 AM	0.55
10/13/2025	10:15:00 AM	0.55
10/13/2025	10:30:00 AM	0.55
10/13/2025	10:45:00 AM	0.55

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/13/2025	11:00:00 AM	0.55
10/13/2025	11:15:00 AM	0.55
10/13/2025	11:30:00 AM	0.55
10/13/2025	11:45:00 AM	0.55
10/13/2025	12:00:00 PM	0.55
10/13/2025	12:15:00 PM	0.55
10/13/2025	12:30:00 PM	0.55
10/13/2025	12:45:00 PM	0.55
10/13/2025	1:00:00 PM	0.55
10/13/2025	1:15:00 PM	0.55
10/13/2025	1:30:00 PM	0.55
10/13/2025	1:45:00 PM	0.55
10/13/2025	2:00:00 PM	0.55
10/13/2025	2:15:00 PM	0.55
10/13/2025	2:30:00 PM	0.55
10/13/2025	2:45:00 PM	0.55
10/13/2025	3:00:00 PM	0.55
10/13/2025	3:15:00 PM	0.55
10/13/2025	3:30:00 PM	0.55
10/13/2025	3:45:00 PM	0.55
10/13/2025	4:00:00 PM	0.55
10/13/2025	4:15:00 PM	0.54
10/13/2025	4:30:00 PM	0.54
10/13/2025	4:45:00 PM	0.54
10/13/2025	5:00:00 PM	0.54
10/13/2025	5:15:00 PM	0.54
10/13/2025	5:30:00 PM	0.54
10/13/2025	5:45:00 PM	0.55
10/13/2025	6:00:00 PM	0.55
10/13/2025	6:15:00 PM	0.55
10/13/2025	6:30:00 PM	0.55
10/13/2025	6:45:00 PM	0.55
10/13/2025	7:00:00 PM	0.55
10/13/2025	7:15:00 PM	0.55
10/13/2025	7:30:00 PM	0.55
10/13/2025	7:45:00 PM	0.55
10/13/2025	8:00:00 PM	0.55
10/13/2025	8:15:00 PM	0.55
10/13/2025	8:30:00 PM	0.55
10/13/2025	8:45:00 PM	0.55
10/13/2025	9:00:00 PM	0.55
10/13/2025	9:15:00 PM	0.55
10/13/2025	9:30:00 PM	0.55
10/13/2025	9:45:00 PM	0.55
10/13/2025	10:00:00 PM	0.54
10/13/2025	10:15:00 PM	0.54

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/13/2025	10:30:00 PM	0.54
10/13/2025	10:45:00 PM	0.54
10/13/2025	11:00:00 PM	0.54
10/13/2025	11:15:00 PM	0.54
10/13/2025	11:30:00 PM	0.54
10/13/2025	11:45:00 PM	0.54
10/14/2025	12:00:00 AM	0.54
10/14/2025	12:15:00 AM	0.54
10/14/2025	12:30:00 AM	0.54
10/14/2025	12:45:00 AM	0.54
10/14/2025	1:00:00 AM	0.54
10/14/2025	1:15:00 AM	0.54
10/14/2025	1:30:00 AM	0.54
10/14/2025	1:45:00 AM	0.53
10/14/2025	2:00:00 AM	0.53
10/14/2025	2:15:00 AM	0.53
10/14/2025	2:30:00 AM	0.53
10/14/2025	2:45:00 AM	0.53
10/14/2025	3:00:00 AM	0.53
10/14/2025	3:15:00 AM	0.53
10/14/2025	3:30:00 AM	0.53
10/14/2025	3:45:00 AM	0.53
10/14/2025	4:00:00 AM	0.53
10/14/2025	4:15:00 AM	0.53
10/14/2025	4:30:00 AM	0.54
10/14/2025	4:45:00 AM	0.54
10/14/2025	5:00:00 AM	0.54
10/14/2025	5:15:00 AM	0.53
10/14/2025	5:30:00 AM	0.53
10/14/2025	5:45:00 AM	0.53
10/14/2025	6:00:00 AM	0.53
10/14/2025	6:15:00 AM	0.53
10/14/2025	6:30:00 AM	0.53
10/14/2025	6:45:00 AM	0.53
10/14/2025	7:00:00 AM	0.53
10/14/2025	7:15:00 AM	0.53
10/14/2025	7:30:00 AM	0.53
10/14/2025	7:45:00 AM	0.53
10/14/2025	8:00:00 AM	0.53
10/14/2025	8:15:00 AM	0.53
10/14/2025	8:30:00 AM	0.54
10/14/2025	8:45:00 AM	0.54
10/14/2025	9:00:00 AM	0.54
10/14/2025	9:15:00 AM	0.54
10/14/2025	9:30:00 AM	0.54
10/14/2025	9:45:00 AM	0.54

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/14/2025	10:00:00 AM	0.54
10/14/2025	10:15:00 AM	0.54
10/14/2025	10:30:00 AM	0.54
10/14/2025	10:45:00 AM	0.54
10/14/2025	11:00:00 AM	0.55
10/14/2025	11:15:00 AM	0.55
10/14/2025	11:30:00 AM	0.55
10/14/2025	11:45:00 AM	0.55
10/14/2025	12:00:00 PM	0.55
10/14/2025	12:15:00 PM	0.55
10/14/2025	12:30:00 PM	0.55
10/14/2025	12:45:00 PM	0.55
10/14/2025	1:00:00 PM	0.55
10/14/2025	1:15:00 PM	0.55
10/14/2025	1:30:00 PM	0.56
10/14/2025	1:45:00 PM	0.56
10/14/2025	2:00:00 PM	0.56
10/14/2025	2:15:00 PM	0.56
10/14/2025	2:30:00 PM	0.56
10/14/2025	2:45:00 PM	0.56
10/14/2025	3:00:00 PM	0.56
10/14/2025	3:15:00 PM	0.56
10/14/2025	3:30:00 PM	0.56
10/14/2025	3:45:00 PM	0.56
10/14/2025	4:00:00 PM	0.56
10/14/2025	4:15:00 PM	0.56
10/14/2025	4:30:00 PM	0.55
10/14/2025	4:45:00 PM	0.55
10/14/2025	5:00:00 PM	0.55
10/14/2025	5:15:00 PM	0.55
10/14/2025	5:30:00 PM	0.55
10/14/2025	5:45:00 PM	0.55
10/14/2025	6:00:00 PM	0.55
10/14/2025	6:15:00 PM	0.55
10/14/2025	6:30:00 PM	0.55
10/14/2025	6:45:00 PM	0.55
10/14/2025	7:00:00 PM	0.55
10/14/2025	7:15:00 PM	0.55
10/14/2025	7:30:00 PM	0.55
10/14/2025	7:45:00 PM	0.55
10/14/2025	8:00:00 PM	0.55
10/14/2025	8:15:00 PM	0.55
10/14/2025	8:30:00 PM	0.55
10/14/2025	8:45:00 PM	0.55
10/14/2025	9:00:00 PM	0.55
10/14/2025	9:15:00 PM	0.55

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/14/2025	9:30:00 PM	0.55
10/14/2025	9:45:00 PM	0.55
10/14/2025	10:00:00 PM	0.55
10/14/2025	10:15:00 PM	0.55
10/14/2025	10:30:00 PM	0.55
10/14/2025	10:45:00 PM	0.55
10/14/2025	11:00:00 PM	0.55
10/14/2025	11:15:00 PM	0.55
10/14/2025	11:30:00 PM	0.55
10/14/2025	11:45:00 PM	0.55
10/15/2025	12:00:00 AM	0.55
10/15/2025	12:15:00 AM	0.55
10/15/2025	12:30:00 AM	0.55
10/15/2025	12:45:00 AM	0.55
10/15/2025	1:00:00 AM	0.55
10/15/2025	1:15:00 AM	0.55
10/15/2025	1:30:00 AM	0.55
10/15/2025	1:45:00 AM	0.55
10/15/2025	2:00:00 AM	0.55
10/15/2025	2:15:00 AM	0.55
10/15/2025	2:30:00 AM	0.55
10/15/2025	2:45:00 AM	0.55
10/15/2025	3:00:00 AM	0.55
10/15/2025	3:15:00 AM	0.55
10/15/2025	3:30:00 AM	0.55
10/15/2025	3:45:00 AM	0.55
10/15/2025	4:00:00 AM	0.56
10/15/2025	4:15:00 AM	0.56
10/15/2025	4:30:00 AM	0.56
10/15/2025	4:45:00 AM	0.56
10/15/2025	5:00:00 AM	0.56
10/15/2025	5:15:00 AM	0.56
10/15/2025	5:30:00 AM	0.56
10/15/2025	5:45:00 AM	0.56
10/15/2025	6:00:00 AM	0.56
10/15/2025	6:15:00 AM	0.56
10/15/2025	6:30:00 AM	0.56
10/15/2025	6:45:00 AM	0.56
10/15/2025	7:00:00 AM	0.56
10/15/2025	7:15:00 AM	0.56
10/15/2025	7:30:00 AM	0.56
10/15/2025	7:45:00 AM	0.56
10/15/2025	8:00:00 AM	0.56
10/15/2025	8:15:00 AM	0.56
10/15/2025	8:30:00 AM	0.56
10/15/2025	8:45:00 AM	0.56

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/15/2025	9:00:00 AM	0.57
10/15/2025	9:15:00 AM	0.57
10/15/2025	9:30:00 AM	0.57
10/15/2025	9:45:00 AM	0.57
10/15/2025	10:00:00 AM	0.57
10/15/2025	10:15:00 AM	0.57
10/15/2025	10:30:00 AM	0.57
10/15/2025	10:45:00 AM	0.57
10/15/2025	11:00:00 AM	0.57
10/15/2025	11:15:00 AM	0.57
10/15/2025	11:30:00 AM	0.57
10/15/2025	11:45:00 AM	0.57
10/15/2025	12:00:00 PM	0.57
10/15/2025	12:15:00 PM	0.57
10/15/2025	12:30:00 PM	0.57
10/15/2025	12:45:00 PM	0.57
10/15/2025	1:00:00 PM	0.57
10/15/2025	1:15:00 PM	0.57
10/15/2025	1:30:00 PM	0.57
10/15/2025	1:45:00 PM	0.57
10/15/2025	2:00:00 PM	0.57
10/15/2025	2:15:00 PM	0.57
10/15/2025	2:30:00 PM	0.57
10/15/2025	2:45:00 PM	0.57
10/15/2025	3:00:00 PM	0.57
10/15/2025	3:15:00 PM	0.57
10/15/2025	3:30:00 PM	0.57
10/15/2025	3:45:00 PM	0.57
10/15/2025	4:00:00 PM	0.57
10/15/2025	4:15:00 PM	0.57
10/15/2025	4:30:00 PM	0.57
10/15/2025	4:45:00 PM	0.57
10/15/2025	5:00:00 PM	0.57
10/15/2025	5:15:00 PM	0.57
10/15/2025	5:30:00 PM	0.57
10/15/2025	5:45:00 PM	0.57
10/15/2025	6:00:00 PM	0.57
10/15/2025	6:15:00 PM	0.57
10/15/2025	6:30:00 PM	0.57
10/15/2025	6:45:00 PM	0.57
10/15/2025	7:00:00 PM	0.57
10/15/2025	7:15:00 PM	0.57
10/15/2025	7:30:00 PM	0.57
10/15/2025	7:45:00 PM	0.56
10/15/2025	8:00:00 PM	0.56
10/15/2025	8:15:00 PM	0.56

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/15/2025	8:30:00 PM	0.56
10/15/2025	8:45:00 PM	0.56
10/15/2025	9:00:00 PM	0.56
10/15/2025	9:15:00 PM	0.56
10/15/2025	9:30:00 PM	0.56
10/15/2025	9:45:00 PM	0.56
10/15/2025	10:00:00 PM	0.56
10/15/2025	10:15:00 PM	0.56
10/15/2025	10:30:00 PM	0.56
10/15/2025	10:45:00 PM	0.56
10/15/2025	11:00:00 PM	0.56
10/15/2025	11:15:00 PM	0.56
10/15/2025	11:30:00 PM	0.56
10/15/2025	11:45:00 PM	0.56
10/16/2025	12:00:00 AM	0.56
10/16/2025	12:15:00 AM	0.56
10/16/2025	12:30:00 AM	0.56
10/16/2025	12:45:00 AM	0.56
10/16/2025	1:00:00 AM	0.56
10/16/2025	1:15:00 AM	0.56
10/16/2025	1:30:00 AM	0.56
10/16/2025	1:45:00 AM	0.56
10/16/2025	2:00:00 AM	0.56
10/16/2025	2:15:00 AM	0.56
10/16/2025	2:30:00 AM	0.56
10/16/2025	2:45:00 AM	0.56
10/16/2025	3:00:00 AM	0.56
10/16/2025	3:15:00 AM	0.56
10/16/2025	3:30:00 AM	0.56
10/16/2025	3:45:00 AM	0.56
10/16/2025	4:00:00 AM	0.56
10/16/2025	4:15:00 AM	0.56
10/16/2025	4:30:00 AM	0.56
10/16/2025	4:45:00 AM	0.56
10/16/2025	5:00:00 AM	0.56
10/16/2025	5:15:00 AM	0.56
10/16/2025	5:30:00 AM	0.56
10/16/2025	5:45:00 AM	0.56
10/16/2025	6:00:00 AM	0.56
10/16/2025	6:15:00 AM	0.56
10/16/2025	6:30:00 AM	0.55
10/16/2025	6:45:00 AM	0.55
10/16/2025	7:00:00 AM	0.55
10/16/2025	7:15:00 AM	0.55
10/16/2025	7:30:00 AM	0.55
10/16/2025	7:45:00 AM	0.55

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/16/2025	8:00:00 AM	0.55
10/16/2025	8:15:00 AM	0.55
10/16/2025	8:30:00 AM	0.55
10/16/2025	8:45:00 AM	0.55
10/16/2025	9:00:00 AM	0.55
10/16/2025	9:15:00 AM	0.55
10/16/2025	9:30:00 AM	0.55
10/16/2025	9:45:00 AM	0.55
10/16/2025	10:00:00 AM	0.55
10/16/2025	10:15:00 AM	0.55
10/16/2025	10:30:00 AM	0.55
10/16/2025	10:45:00 AM	0.55
10/16/2025	11:00:00 AM	0.55
10/16/2025	11:15:00 AM	0.55
10/16/2025	11:30:00 AM	0.55
10/16/2025	11:45:00 AM	0.55
10/16/2025	12:00:00 PM	0.55
10/16/2025	12:15:00 PM	0.55
10/16/2025	12:30:00 PM	0.55
10/16/2025	12:45:00 PM	0.55
10/16/2025	1:00:00 PM	0.55
10/16/2025	1:15:00 PM	0.55
10/16/2025	1:30:00 PM	0.55
10/16/2025	1:45:00 PM	0.55
10/16/2025	2:00:00 PM	0.55
10/16/2025	2:15:00 PM	0.55
10/16/2025	2:30:00 PM	0.55
10/16/2025	2:45:00 PM	0.55
10/16/2025	3:00:00 PM	0.55
10/16/2025	3:15:00 PM	0.55
10/16/2025	3:30:00 PM	0.55
10/16/2025	3:45:00 PM	0.55
10/16/2025	4:00:00 PM	0.55
10/16/2025	4:15:00 PM	0.55
10/16/2025	4:30:00 PM	0.55
10/16/2025	4:45:00 PM	0.55
10/16/2025	5:00:00 PM	0.55
10/16/2025	5:15:00 PM	0.55
10/16/2025	5:30:00 PM	0.55
10/16/2025	5:45:00 PM	0.55
10/16/2025	6:00:00 PM	0.55
10/16/2025	6:15:00 PM	0.55
10/16/2025	6:30:00 PM	0.55
10/16/2025	6:45:00 PM	0.55
10/16/2025	7:00:00 PM	0.55
10/16/2025	7:15:00 PM	0.55

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/16/2025	7:30:00 PM	0.55
10/16/2025	7:45:00 PM	0.55
10/16/2025	8:00:00 PM	0.56
10/16/2025	8:15:00 PM	0.55
10/16/2025	8:30:00 PM	0.55
10/16/2025	8:45:00 PM	0.56
10/16/2025	9:00:00 PM	0.56
10/16/2025	9:15:00 PM	0.56
10/16/2025	9:30:00 PM	0.56
10/16/2025	9:45:00 PM	0.56
10/16/2025	10:00:00 PM	0.55
10/16/2025	10:15:00 PM	0.55
10/16/2025	10:30:00 PM	0.55
10/16/2025	10:45:00 PM	0.55
10/16/2025	11:00:00 PM	0.56
10/16/2025	11:15:00 PM	0.56
10/16/2025	11:30:00 PM	0.56
10/16/2025	11:45:00 PM	0.56
10/17/2025	12:00:00 AM	0.56
10/17/2025	12:15:00 AM	0.56
10/17/2025	12:30:00 AM	0.56
10/17/2025	12:45:00 AM	0.56
10/17/2025	1:00:00 AM	0.56
10/17/2025	1:15:00 AM	0.56
10/17/2025	1:30:00 AM	0.56
10/17/2025	1:45:00 AM	0.56
10/17/2025	2:00:00 AM	0.56
10/17/2025	2:15:00 AM	0.56
10/17/2025	2:30:00 AM	0.56
10/17/2025	2:45:00 AM	0.56
10/17/2025	3:00:00 AM	0.55
10/17/2025	3:15:00 AM	0.55
10/17/2025	3:30:00 AM	0.55
10/17/2025	3:45:00 AM	0.55
10/17/2025	4:00:00 AM	0.55
10/17/2025	4:15:00 AM	0.55
10/17/2025	4:30:00 AM	0.55
10/17/2025	4:45:00 AM	0.55
10/17/2025	5:00:00 AM	0.55
10/17/2025	5:15:00 AM	0.55
10/17/2025	5:30:00 AM	0.55
10/17/2025	5:45:00 AM	0.55
10/17/2025	6:00:00 AM	0.55
10/17/2025	6:15:00 AM	0.55
10/17/2025	6:30:00 AM	0.55
10/17/2025	6:45:00 AM	0.55

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/17/2025	7:00:00 AM	0.55
10/17/2025	7:15:00 AM	0.55
10/17/2025	7:30:00 AM	0.55
10/17/2025	7:45:00 AM	0.55
10/17/2025	8:00:00 AM	0.55
10/17/2025	8:15:00 AM	0.55
10/17/2025	8:30:00 AM	0.55
10/17/2025	8:45:00 AM	0.55
10/17/2025	9:00:00 AM	0.55
10/17/2025	9:15:00 AM	0.55
10/17/2025	9:30:00 AM	0.55
10/17/2025	9:45:00 AM	0.55
10/17/2025	10:00:00 AM	0.55
10/17/2025	10:15:00 AM	0.55
10/17/2025	10:30:00 AM	0.55
10/17/2025	10:45:00 AM	0.55
10/17/2025	11:00:00 AM	0.55
10/17/2025	11:15:00 AM	0.55
10/17/2025	11:30:00 AM	0.56
10/17/2025	11:45:00 AM	0.55
10/17/2025	12:00:00 PM	0.55
10/17/2025	12:15:00 PM	0.55
10/17/2025	12:30:00 PM	0.55
10/17/2025	12:45:00 PM	0.55
10/17/2025	1:00:00 PM	0.55
10/17/2025	1:15:00 PM	0.55
10/17/2025	1:30:00 PM	0.55
10/17/2025	1:45:00 PM	0.55
10/17/2025	2:00:00 PM	0.55
10/17/2025	2:15:00 PM	0.55
10/17/2025	2:30:00 PM	0.55
10/17/2025	2:45:00 PM	0.55
10/17/2025	3:00:00 PM	0.55
10/17/2025	3:15:00 PM	0.55
10/17/2025	3:30:00 PM	0.55
10/17/2025	3:45:00 PM	0.55
10/17/2025	4:00:00 PM	0.55
10/17/2025	4:15:00 PM	0.55
10/17/2025	4:30:00 PM	0.55
10/17/2025	4:45:00 PM	0.55
10/17/2025	5:00:00 PM	0.55
10/17/2025	5:15:00 PM	0.55
10/17/2025	5:30:00 PM	0.55
10/17/2025	5:45:00 PM	0.55
10/17/2025	6:00:00 PM	0.55
10/17/2025	6:15:00 PM	0.55

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/17/2025	6:30:00 PM	0.55
10/17/2025	6:45:00 PM	0.55
10/17/2025	7:00:00 PM	0.55
10/17/2025	7:15:00 PM	0.55
10/17/2025	7:30:00 PM	0.55
10/17/2025	7:45:00 PM	0.55
10/17/2025	8:00:00 PM	0.55
10/17/2025	8:15:00 PM	0.55
10/17/2025	8:30:00 PM	0.55
10/17/2025	8:45:00 PM	0.55
10/17/2025	9:00:00 PM	0.55
10/17/2025	9:15:00 PM	0.55
10/17/2025	9:30:00 PM	0.55
10/17/2025	9:45:00 PM	0.55
10/17/2025	10:00:00 PM	0.55
10/17/2025	10:15:00 PM	0.55
10/17/2025	10:30:00 PM	0.55
10/17/2025	10:45:00 PM	0.55
10/17/2025	11:00:00 PM	0.55
10/17/2025	11:15:00 PM	0.55
10/17/2025	11:30:00 PM	0.55
10/17/2025	11:45:00 PM	0.55
10/18/2025	12:00:00 AM	0.55
10/18/2025	12:15:00 AM	0.55
10/18/2025	12:30:00 AM	0.55
10/18/2025	12:45:00 AM	0.55
10/18/2025	1:00:00 AM	0.55
10/18/2025	1:15:00 AM	0.55
10/18/2025	1:30:00 AM	0.55
10/18/2025	1:45:00 AM	0.55
10/18/2025	2:00:00 AM	0.55
10/18/2025	2:15:00 AM	0.55
10/18/2025	2:30:00 AM	0.55
10/18/2025	2:45:00 AM	0.55
10/18/2025	3:00:00 AM	0.55
10/18/2025	3:15:00 AM	0.55
10/18/2025	3:30:00 AM	0.55
10/18/2025	3:45:00 AM	0.55
10/18/2025	4:00:00 AM	0.55
10/18/2025	4:15:00 AM	0.55
10/18/2025	4:30:00 AM	0.55
10/18/2025	4:45:00 AM	0.55
10/18/2025	5:00:00 AM	0.55
10/18/2025	5:15:00 AM	0.55
10/18/2025	5:30:00 AM	0.55
10/18/2025	5:45:00 AM	0.55

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/18/2025	6:00:00 AM	0.55
10/18/2025	6:15:00 AM	0.55
10/18/2025	6:30:00 AM	0.55
10/18/2025	6:45:00 AM	0.55
10/18/2025	7:00:00 AM	0.55
10/18/2025	7:15:00 AM	0.55
10/18/2025	7:30:00 AM	0.55
10/18/2025	7:45:00 AM	0.55
10/18/2025	8:00:00 AM	0.55
10/18/2025	8:15:00 AM	0.55
10/18/2025	8:30:00 AM	0.55
10/18/2025	8:45:00 AM	0.55
10/18/2025	9:00:00 AM	0.55
10/18/2025	9:15:00 AM	0.55
10/18/2025	9:30:00 AM	0.55
10/18/2025	9:45:00 AM	0.56
10/18/2025	10:00:00 AM	0.55
10/18/2025	10:15:00 AM	0.55
10/18/2025	10:30:00 AM	0.55
10/18/2025	10:45:00 AM	0.56
10/18/2025	11:00:00 AM	0.56
10/18/2025	11:15:00 AM	0.55
10/18/2025	11:30:00 AM	0.55
10/18/2025	11:45:00 AM	0.55
10/18/2025	12:00:00 PM	0.56
10/18/2025	12:15:00 PM	0.56
10/18/2025	12:30:00 PM	0.55
10/18/2025	12:45:00 PM	0.56
10/18/2025	1:00:00 PM	0.55
10/18/2025	1:15:00 PM	0.55
10/18/2025	1:30:00 PM	0.55
10/18/2025	1:45:00 PM	0.55
10/18/2025	2:00:00 PM	0.55
10/18/2025	2:15:00 PM	0.56
10/18/2025	2:30:00 PM	0.55
10/18/2025	2:45:00 PM	0.55
10/18/2025	3:00:00 PM	0.55
10/18/2025	3:15:00 PM	0.55
10/18/2025	3:30:00 PM	0.55
10/18/2025	3:45:00 PM	0.55
10/18/2025	4:00:00 PM	0.55
10/18/2025	4:15:00 PM	0.55
10/18/2025	4:30:00 PM	0.55
10/18/2025	4:45:00 PM	0.55
10/18/2025	5:00:00 PM	0.55
10/18/2025	5:15:00 PM	0.55

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/18/2025	5:30:00 PM	0.55
10/18/2025	5:45:00 PM	0.55
10/18/2025	6:00:00 PM	0.55
10/18/2025	6:15:00 PM	0.55
10/18/2025	6:30:00 PM	0.55
10/18/2025	6:45:00 PM	0.55
10/18/2025	7:00:00 PM	0.55
10/18/2025	7:15:00 PM	0.55
10/18/2025	7:30:00 PM	0.55
10/18/2025	7:45:00 PM	0.55
10/18/2025	8:00:00 PM	0.55
10/18/2025	8:15:00 PM	0.55
10/18/2025	8:30:00 PM	0.55
10/18/2025	8:45:00 PM	0.55
10/18/2025	9:00:00 PM	0.55
10/18/2025	9:15:00 PM	0.55
10/18/2025	9:30:00 PM	0.55
10/18/2025	9:45:00 PM	0.55
10/18/2025	10:00:00 PM	0.55
10/18/2025	10:15:00 PM	0.55
10/18/2025	10:30:00 PM	0.56
10/18/2025	10:45:00 PM	0.55
10/18/2025	11:00:00 PM	0.55
10/18/2025	11:15:00 PM	0.55
10/18/2025	11:30:00 PM	0.56
10/18/2025	11:45:00 PM	0.56
10/19/2025	12:00:00 AM	0.56
10/19/2025	12:15:00 AM	0.56
10/19/2025	12:30:00 AM	0.56
10/19/2025	12:45:00 AM	0.56
10/19/2025	1:00:00 AM	0.56
10/19/2025	1:15:00 AM	0.56
10/19/2025	1:30:00 AM	0.56
10/19/2025	1:45:00 AM	0.56
10/19/2025	2:00:00 AM	0.56
10/19/2025	2:15:00 AM	0.56
10/19/2025	2:30:00 AM	0.56
10/19/2025	2:45:00 AM	0.56
10/19/2025	3:00:00 AM	0.56
10/19/2025	3:15:00 AM	0.56
10/19/2025	3:30:00 AM	0.56
10/19/2025	3:45:00 AM	0.56
10/19/2025	4:00:00 AM	0.56
10/19/2025	4:15:00 AM	0.56
10/19/2025	4:30:00 AM	0.56
10/19/2025	4:45:00 AM	0.56

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/19/2025	5:00:00 AM	0.56
10/19/2025	5:15:00 AM	0.56
10/19/2025	5:30:00 AM	0.56
10/19/2025	5:45:00 AM	0.56
10/19/2025	6:00:00 AM	0.56
10/19/2025	6:15:00 AM	0.56
10/19/2025	6:30:00 AM	0.56
10/19/2025	6:45:00 AM	0.56
10/19/2025	7:00:00 AM	0.56
10/19/2025	7:15:00 AM	0.56
10/19/2025	7:30:00 AM	0.56
10/19/2025	7:45:00 AM	0.56
10/19/2025	8:00:00 AM	0.56
10/19/2025	8:15:00 AM	0.56
10/19/2025	8:30:00 AM	0.56
10/19/2025	8:45:00 AM	0.57
10/19/2025	9:00:00 AM	0.57
10/19/2025	9:15:00 AM	0.57
10/19/2025	9:30:00 AM	0.57
10/19/2025	9:45:00 AM	0.57
10/19/2025	10:00:00 AM	0.57
10/19/2025	10:15:00 AM	0.57
10/19/2025	10:30:00 AM	0.57
10/19/2025	10:45:00 AM	0.57
10/19/2025	11:00:00 AM	0.57
10/19/2025	11:15:00 AM	0.57
10/19/2025	11:30:00 AM	0.57
10/19/2025	11:45:00 AM	0.57
10/19/2025	12:00:00 PM	0.57
10/19/2025	12:15:00 PM	0.57
10/19/2025	12:30:00 PM	0.57
10/19/2025	12:45:00 PM	0.57
10/19/2025	1:00:00 PM	0.57
10/19/2025	1:15:00 PM	0.57
10/19/2025	1:30:00 PM	0.57
10/19/2025	1:45:00 PM	0.57
10/19/2025	2:00:00 PM	0.57
10/19/2025	2:15:00 PM	0.57
10/19/2025	2:30:00 PM	0.57
10/19/2025	2:45:00 PM	0.57
10/19/2025	3:00:00 PM	0.57
10/19/2025	3:15:00 PM	0.57
10/19/2025	3:30:00 PM	0.57
10/19/2025	3:45:00 PM	0.57
10/19/2025	4:00:00 PM	0.57
10/19/2025	4:15:00 PM	0.57

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/19/2025	4:30:00 PM	0.57
10/19/2025	4:45:00 PM	0.57
10/19/2025	5:00:00 PM	0.57
10/19/2025	5:15:00 PM	0.57
10/19/2025	5:30:00 PM	0.57
10/19/2025	5:45:00 PM	0.57
10/19/2025	6:00:00 PM	0.57
10/19/2025	6:15:00 PM	0.57
10/19/2025	6:30:00 PM	0.57
10/19/2025	6:45:00 PM	0.57
10/19/2025	7:00:00 PM	0.57
10/19/2025	7:15:00 PM	0.57
10/19/2025	7:30:00 PM	0.57
10/19/2025	7:45:00 PM	0.57
10/19/2025	8:00:00 PM	0.57
10/19/2025	8:15:00 PM	0.57
10/19/2025	8:30:00 PM	0.57
10/19/2025	8:45:00 PM	0.57
10/19/2025	9:00:00 PM	0.57
10/19/2025	9:15:00 PM	0.57
10/19/2025	9:30:00 PM	0.57
10/19/2025	9:45:00 PM	0.57
10/19/2025	10:00:00 PM	0.57
10/19/2025	10:15:00 PM	0.57
10/19/2025	10:30:00 PM	0.57
10/19/2025	10:45:00 PM	0.57
10/19/2025	11:00:00 PM	0.57
10/19/2025	11:15:00 PM	0.57
10/19/2025	11:30:00 PM	0.57
10/19/2025	11:45:00 PM	0.57
10/20/2025	12:00:00 AM	0.57
10/20/2025	12:15:00 AM	0.57
10/20/2025	12:30:00 AM	0.57
10/20/2025	12:45:00 AM	0.57
10/20/2025	1:00:00 AM	0.57
10/20/2025	1:15:00 AM	0.57
10/20/2025	1:30:00 AM	0.57
10/20/2025	1:45:00 AM	0.57
10/20/2025	2:00:00 AM	0.57
10/20/2025	2:15:00 AM	0.57
10/20/2025	2:30:00 AM	0.57
10/20/2025	2:45:00 AM	0.57
10/20/2025	3:00:00 AM	0.57
10/20/2025	3:15:00 AM	0.57
10/20/2025	3:30:00 AM	0.57
10/20/2025	3:45:00 AM	0.57

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/20/2025	4:00:00 AM	0.57
10/20/2025	4:15:00 AM	0.57
10/20/2025	4:30:00 AM	0.57
10/20/2025	4:45:00 AM	0.57
10/20/2025	5:00:00 AM	0.57
10/20/2025	5:15:00 AM	0.57
10/20/2025	5:30:00 AM	0.57
10/20/2025	5:45:00 AM	0.57
10/20/2025	6:00:00 AM	0.57
10/20/2025	6:15:00 AM	0.57
10/20/2025	6:30:00 AM	0.57
10/20/2025	6:45:00 AM	0.57
10/20/2025	7:00:00 AM	0.57
10/20/2025	7:15:00 AM	0.57
10/20/2025	7:30:00 AM	0.57
10/20/2025	7:45:00 AM	0.57
10/20/2025	8:00:00 AM	0.57
10/20/2025	8:15:00 AM	0.57
10/20/2025	8:30:00 AM	0.57
10/20/2025	8:45:00 AM	0.57
10/20/2025	9:00:00 AM	0.57
10/20/2025	9:15:00 AM	0.57
10/20/2025	9:30:00 AM	0.57
10/20/2025	9:45:00 AM	0.57
10/20/2025	10:00:00 AM	0.58
10/20/2025	10:15:00 AM	0.58
10/20/2025	10:30:00 AM	0.58
10/20/2025	10:45:00 AM	0.58
10/20/2025	11:00:00 AM	0.58
10/20/2025	11:15:00 AM	0.58
10/20/2025	11:30:00 AM	0.58
10/20/2025	11:45:00 AM	0.58
10/20/2025	12:00:00 PM	0.58
10/20/2025	12:15:00 PM	0.58
10/20/2025	12:30:00 PM	0.58
10/20/2025	12:45:00 PM	0.58
10/20/2025	1:00:00 PM	0.58
10/20/2025	1:15:00 PM	0.58
10/20/2025	1:30:00 PM	0.58
10/20/2025	1:45:00 PM	0.58
10/20/2025	2:00:00 PM	0.58
10/20/2025	2:15:00 PM	0.58
10/20/2025	2:30:00 PM	0.58
10/20/2025	2:45:00 PM	0.58
10/20/2025	3:00:00 PM	0.57
10/20/2025	3:15:00 PM	0.58

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/20/2025	3:30:00 PM	0.58
10/20/2025	3:45:00 PM	0.58
10/20/2025	4:00:00 PM	0.58
10/20/2025	4:15:00 PM	0.57
10/20/2025	4:30:00 PM	0.58
10/20/2025	4:45:00 PM	0.57
10/20/2025	5:00:00 PM	0.57
10/20/2025	5:15:00 PM	0.57
10/20/2025	5:30:00 PM	0.57
10/20/2025	5:45:00 PM	0.57
10/20/2025	6:00:00 PM	0.57
10/20/2025	6:15:00 PM	0.57
10/20/2025	6:30:00 PM	0.57
10/20/2025	6:45:00 PM	0.57
10/20/2025	7:00:00 PM	0.57
10/20/2025	7:15:00 PM	0.57
10/20/2025	7:30:00 PM	0.57
10/20/2025	7:45:00 PM	0.57
10/20/2025	8:00:00 PM	0.57
10/20/2025	8:15:00 PM	0.57
10/20/2025	8:30:00 PM	0.57
10/20/2025	8:45:00 PM	0.57
10/20/2025	9:00:00 PM	0.57
10/20/2025	9:15:00 PM	0.57
10/20/2025	9:30:00 PM	0.57
10/20/2025	9:45:00 PM	0.57
10/20/2025	10:00:00 PM	0.57
10/20/2025	10:15:00 PM	0.57
10/20/2025	10:30:00 PM	0.57
10/20/2025	10:45:00 PM	0.57
10/20/2025	11:00:00 PM	0.57
10/20/2025	11:15:00 PM	0.57
10/20/2025	11:30:00 PM	0.57
10/20/2025	11:45:00 PM	0.57
10/21/2025	12:00:00 AM	0.57
10/21/2025	12:15:00 AM	0.57
10/21/2025	12:30:00 AM	0.57
10/21/2025	12:45:00 AM	0.57
10/21/2025	1:00:00 AM	0.57
10/21/2025	1:15:00 AM	0.57
10/21/2025	1:30:00 AM	0.57
10/21/2025	1:45:00 AM	0.57
10/21/2025	2:00:00 AM	0.57
10/21/2025	2:15:00 AM	0.57
10/21/2025	2:30:00 AM	0.57
10/21/2025	2:45:00 AM	0.57

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/21/2025	3:00:00 AM	0.57
10/21/2025	3:15:00 AM	0.57
10/21/2025	3:30:00 AM	0.57
10/21/2025	3:45:00 AM	0.57
10/21/2025	4:00:00 AM	0.57
10/21/2025	4:15:00 AM	0.57
10/21/2025	4:30:00 AM	0.57
10/21/2025	4:45:00 AM	0.57
10/21/2025	5:00:00 AM	0.57
10/21/2025	5:15:00 AM	0.57
10/21/2025	5:30:00 AM	0.57
10/21/2025	5:45:00 AM	0.57
10/21/2025	6:00:00 AM	0.57
10/21/2025	6:15:00 AM	0.57
10/21/2025	6:30:00 AM	0.57
10/21/2025	6:45:00 AM	0.57
10/21/2025	7:00:00 AM	0.57
10/21/2025	7:15:00 AM	0.57
10/21/2025	7:30:00 AM	0.57
10/21/2025	7:45:00 AM	0.57
10/21/2025	8:00:00 AM	0.56
10/21/2025	8:15:00 AM	0.56
10/21/2025	8:30:00 AM	0.56
10/21/2025	8:45:00 AM	0.56
10/21/2025	9:00:00 AM	0.56
10/21/2025	9:15:00 AM	0.56
10/21/2025	9:30:00 AM	0.56
10/21/2025	9:45:00 AM	0.56
10/21/2025	10:00:00 AM	0.56
10/21/2025	10:15:00 AM	0.56
10/21/2025	10:30:00 AM	0.56
10/21/2025	10:45:00 AM	0.56
10/21/2025	11:00:00 AM	0.56
10/21/2025	11:15:00 AM	0.56
10/21/2025	11:30:00 AM	0.56
10/21/2025	11:45:00 AM	0.56
10/21/2025	12:00:00 PM	0.56
10/21/2025	12:15:00 PM	0.56
10/21/2025	12:30:00 PM	0.56
10/21/2025	12:45:00 PM	0.56
10/21/2025	1:00:00 PM	0.56
10/21/2025	1:15:00 PM	0.56
10/21/2025	1:30:00 PM	0.56
10/21/2025	1:45:00 PM	0.56
10/21/2025	2:00:00 PM	0.56
10/21/2025	2:15:00 PM	0.55

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/21/2025	2:30:00 PM	0.55
10/21/2025	2:45:00 PM	0.55
10/21/2025	3:00:00 PM	0.55
10/21/2025	3:15:00 PM	0.55
10/21/2025	3:30:00 PM	0.55
10/21/2025	3:45:00 PM	0.55
10/21/2025	4:00:00 PM	0.55
10/21/2025	4:15:00 PM	0.55
10/21/2025	4:30:00 PM	0.55
10/21/2025	4:45:00 PM	0.55
10/21/2025	5:00:00 PM	0.55
10/21/2025	5:15:00 PM	0.55
10/21/2025	5:30:00 PM	0.55
10/21/2025	5:45:00 PM	0.55
10/21/2025	6:00:00 PM	0.55
10/21/2025	6:15:00 PM	0.55
10/21/2025	6:30:00 PM	0.55
10/21/2025	6:45:00 PM	0.55
10/21/2025	7:00:00 PM	0.55
10/21/2025	7:15:00 PM	0.55
10/21/2025	7:30:00 PM	0.55
10/21/2025	7:45:00 PM	0.55
10/21/2025	8:00:00 PM	0.55
10/21/2025	8:15:00 PM	0.55
10/21/2025	8:30:00 PM	0.54
10/21/2025	8:45:00 PM	0.55
10/21/2025	9:00:00 PM	0.55
10/21/2025	9:15:00 PM	0.55
10/21/2025	9:30:00 PM	0.54
10/21/2025	9:45:00 PM	0.54
10/21/2025	10:00:00 PM	0.54
10/21/2025	10:15:00 PM	0.54
10/21/2025	10:30:00 PM	0.54
10/21/2025	10:45:00 PM	0.54
10/21/2025	11:00:00 PM	0.54
10/21/2025	11:15:00 PM	0.54
10/21/2025	11:30:00 PM	0.54
10/21/2025	11:45:00 PM	0.54
10/22/2025	12:00:00 AM	0.54
10/22/2025	12:15:00 AM	0.54
10/22/2025	12:30:00 AM	0.54
10/22/2025	12:45:00 AM	0.54
10/22/2025	1:00:00 AM	0.54
10/22/2025	1:15:00 AM	0.54
10/22/2025	1:30:00 AM	0.54
10/22/2025	1:45:00 AM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/22/2025	2:00:00 AM	0.53
10/22/2025	2:15:00 AM	0.53
10/22/2025	2:30:00 AM	0.53
10/22/2025	2:45:00 AM	0.53
10/22/2025	3:00:00 AM	0.53
10/22/2025	3:15:00 AM	0.53
10/22/2025	3:30:00 AM	0.53
10/22/2025	3:45:00 AM	0.53
10/22/2025	4:00:00 AM	0.52
10/22/2025	4:15:00 AM	0.52
10/22/2025	4:30:00 AM	0.52
10/22/2025	4:45:00 AM	0.52
10/22/2025	5:00:00 AM	0.52
10/22/2025	5:15:00 AM	0.52
10/22/2025	5:30:00 AM	0.52
10/22/2025	5:45:00 AM	0.52
10/22/2025	6:00:00 AM	0.52
10/22/2025	6:15:00 AM	0.52
10/22/2025	6:30:00 AM	0.52
10/22/2025	6:45:00 AM	0.52
10/22/2025	7:00:00 AM	0.52
10/22/2025	7:15:00 AM	0.52
10/22/2025	7:30:00 AM	0.52
10/22/2025	7:45:00 AM	0.52
10/22/2025	8:00:00 AM	0.52
10/22/2025	8:15:00 AM	0.52
10/22/2025	8:30:00 AM	0.52
10/22/2025	8:45:00 AM	0.52
10/22/2025	9:00:00 AM	0.52
10/22/2025	9:15:00 AM	0.52
10/22/2025	9:30:00 AM	0.52
10/22/2025	9:45:00 AM	0.52
10/22/2025	10:00:00 AM	0.52
10/22/2025	10:15:00 AM	0.52
10/22/2025	10:30:00 AM	0.52
10/22/2025	10:45:00 AM	0.52
10/22/2025	11:00:00 AM	0.52
10/22/2025	11:15:00 AM	0.52
10/22/2025	11:30:00 AM	0.52
10/22/2025	11:45:00 AM	0.52
10/22/2025	12:00:00 PM	0.52
10/22/2025	12:15:00 PM	0.52
10/22/2025	12:30:00 PM	0.52
10/22/2025	12:45:00 PM	0.52
10/22/2025	1:00:00 PM	0.52
10/22/2025	1:15:00 PM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/22/2025	1:30:00 PM	0.52
10/22/2025	1:45:00 PM	0.51
10/22/2025	2:00:00 PM	0.51
10/22/2025	2:15:00 PM	0.51
10/22/2025	2:30:00 PM	0.51
10/22/2025	2:45:00 PM	0.51
10/22/2025	3:00:00 PM	0.51
10/22/2025	3:15:00 PM	0.51
10/22/2025	3:30:00 PM	0.51
10/22/2025	3:45:00 PM	0.51
10/22/2025	4:00:00 PM	0.52
10/22/2025	4:15:00 PM	0.52
10/22/2025	4:30:00 PM	0.52
10/22/2025	4:45:00 PM	0.52
10/22/2025	5:00:00 PM	0.52
10/22/2025	5:15:00 PM	0.52
10/22/2025	5:30:00 PM	0.52
10/22/2025	5:45:00 PM	0.52
10/22/2025	6:00:00 PM	0.52
10/22/2025	6:15:00 PM	0.52
10/22/2025	6:30:00 PM	0.52
10/22/2025	6:45:00 PM	0.52
10/22/2025	7:00:00 PM	0.52
10/22/2025	7:15:00 PM	0.52
10/22/2025	7:30:00 PM	0.52
10/22/2025	7:45:00 PM	0.52
10/22/2025	8:00:00 PM	0.52
10/22/2025	8:15:00 PM	0.52
10/22/2025	8:30:00 PM	0.52
10/22/2025	8:45:00 PM	0.52
10/22/2025	9:00:00 PM	0.52
10/22/2025	9:15:00 PM	0.52
10/22/2025	9:30:00 PM	0.52
10/22/2025	9:45:00 PM	0.52
10/22/2025	10:00:00 PM	0.52
10/22/2025	10:15:00 PM	0.52
10/22/2025	10:30:00 PM	0.52
10/22/2025	10:45:00 PM	0.52
10/22/2025	11:00:00 PM	0.52
10/22/2025	11:15:00 PM	0.52
10/22/2025	11:30:00 PM	0.52
10/22/2025	11:45:00 PM	0.52
10/23/2025	12:00:00 AM	0.52
10/23/2025	12:15:00 AM	0.52
10/23/2025	12:30:00 AM	0.52
10/23/2025	12:45:00 AM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/23/2025	1:00:00 AM	0.52
10/23/2025	1:15:00 AM	0.52
10/23/2025	1:30:00 AM	0.52
10/23/2025	1:45:00 AM	0.52
10/23/2025	2:00:00 AM	0.52
10/23/2025	2:15:00 AM	0.52
10/23/2025	2:30:00 AM	0.52
10/23/2025	2:45:00 AM	0.52
10/23/2025	3:00:00 AM	0.52
10/23/2025	3:15:00 AM	0.52
10/23/2025	3:30:00 AM	0.52
10/23/2025	3:45:00 AM	0.52
10/23/2025	4:00:00 AM	0.52
10/23/2025	4:15:00 AM	0.52
10/23/2025	4:30:00 AM	0.52
10/23/2025	4:45:00 AM	0.52
10/23/2025	5:00:00 AM	0.52
10/23/2025	5:15:00 AM	0.52
10/23/2025	5:30:00 AM	0.52
10/23/2025	5:45:00 AM	0.52
10/23/2025	6:00:00 AM	0.52
10/23/2025	6:15:00 AM	0.52
10/23/2025	6:30:00 AM	0.52
10/23/2025	6:45:00 AM	0.52
10/23/2025	7:00:00 AM	0.52
10/23/2025	7:15:00 AM	0.52
10/23/2025	7:30:00 AM	0.52
10/23/2025	7:45:00 AM	0.52
10/23/2025	8:00:00 AM	0.52
10/23/2025	8:15:00 AM	0.52
10/23/2025	8:30:00 AM	0.52
10/23/2025	8:45:00 AM	0.52
10/23/2025	9:00:00 AM	0.52
10/23/2025	9:15:00 AM	0.52
10/23/2025	9:30:00 AM	0.52
10/23/2025	9:45:00 AM	0.52
10/23/2025	10:00:00 AM	0.52
10/23/2025	10:15:00 AM	0.52
10/23/2025	10:30:00 AM	0.52
10/23/2025	10:45:00 AM	0.52
10/23/2025	11:00:00 AM	0.52
10/23/2025	11:15:00 AM	0.52
10/23/2025	11:30:00 AM	0.52
10/23/2025	11:45:00 AM	0.52
10/23/2025	12:00:00 PM	0.52
10/23/2025	12:15:00 PM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/23/2025	12:30:00 PM	0.52
10/23/2025	12:45:00 PM	0.51
10/23/2025	1:00:00 PM	0.51
10/23/2025	1:15:00 PM	0.51
10/23/2025	1:30:00 PM	0.51
10/23/2025	1:45:00 PM	0.51
10/23/2025	2:00:00 PM	0.51
10/23/2025	2:15:00 PM	0.51
10/23/2025	2:30:00 PM	0.51
10/23/2025	2:45:00 PM	0.51
10/23/2025	3:00:00 PM	0.51
10/23/2025	3:15:00 PM	0.51
10/23/2025	3:30:00 PM	0.51
10/23/2025	3:45:00 PM	0.51
10/23/2025	4:00:00 PM	0.51
10/23/2025	4:15:00 PM	0.51
10/23/2025	4:30:00 PM	0.51
10/23/2025	4:45:00 PM	0.51
10/23/2025	5:00:00 PM	0.51
10/23/2025	5:15:00 PM	0.51
10/23/2025	5:30:00 PM	0.51
10/23/2025	5:45:00 PM	0.51
10/23/2025	6:00:00 PM	0.51
10/23/2025	6:15:00 PM	0.51
10/23/2025	6:30:00 PM	0.51
10/23/2025	6:45:00 PM	0.51
10/23/2025	7:00:00 PM	0.51
10/23/2025	7:15:00 PM	0.51
10/23/2025	7:30:00 PM	0.51
10/23/2025	7:45:00 PM	0.51
10/23/2025	8:00:00 PM	0.51
10/23/2025	8:15:00 PM	0.52
10/23/2025	8:30:00 PM	0.52
10/23/2025	8:45:00 PM	0.52
10/23/2025	9:00:00 PM	0.52
10/23/2025	9:15:00 PM	0.52
10/23/2025	9:30:00 PM	0.52
10/23/2025	9:45:00 PM	0.52
10/23/2025	10:00:00 PM	0.52
10/23/2025	10:15:00 PM	0.52
10/23/2025	10:30:00 PM	0.52
10/23/2025	10:45:00 PM	0.52
10/23/2025	11:00:00 PM	0.52
10/23/2025	11:15:00 PM	0.52
10/23/2025	11:30:00 PM	0.52
10/23/2025	11:45:00 PM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/24/2025	12:00:00 AM	0.52
10/24/2025	12:15:00 AM	0.52
10/24/2025	12:30:00 AM	0.52
10/24/2025	12:45:00 AM	0.52
10/24/2025	1:00:00 AM	0.52
10/24/2025	1:15:00 AM	0.52
10/24/2025	1:30:00 AM	0.52
10/24/2025	1:45:00 AM	0.52
10/24/2025	2:00:00 AM	0.52
10/24/2025	2:15:00 AM	0.52
10/24/2025	2:30:00 AM	0.52
10/24/2025	2:45:00 AM	0.52
10/24/2025	3:00:00 AM	0.52
10/24/2025	3:15:00 AM	0.52
10/24/2025	3:30:00 AM	0.52
10/24/2025	3:45:00 AM	0.52
10/24/2025	4:00:00 AM	0.52
10/24/2025	4:15:00 AM	0.52
10/24/2025	4:30:00 AM	0.52
10/24/2025	4:45:00 AM	0.52
10/24/2025	5:00:00 AM	0.52
10/24/2025	5:15:00 AM	0.52
10/24/2025	5:30:00 AM	0.52
10/24/2025	5:45:00 AM	0.53
10/24/2025	6:00:00 AM	0.53
10/24/2025	6:15:00 AM	0.53
10/24/2025	6:30:00 AM	0.52
10/24/2025	6:45:00 AM	0.53
10/24/2025	7:00:00 AM	0.53
10/24/2025	7:15:00 AM	0.53
10/24/2025	7:30:00 AM	0.53
10/24/2025	7:45:00 AM	0.53
10/24/2025	8:00:00 AM	0.53
10/24/2025	8:15:00 AM	0.53
10/24/2025	8:30:00 AM	0.53
10/24/2025	8:45:00 AM	0.53
10/24/2025	9:00:00 AM	0.53
10/24/2025	9:15:00 AM	0.53
10/24/2025	9:30:00 AM	0.53
10/24/2025	9:45:00 AM	0.53
10/24/2025	10:00:00 AM	0.53
10/24/2025	10:15:00 AM	0.53
10/24/2025	10:30:00 AM	0.53
10/24/2025	10:45:00 AM	0.53
10/24/2025	11:00:00 AM	0.53
10/24/2025	11:15:00 AM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/24/2025	11:30:00 AM	0.53
10/24/2025	11:45:00 AM	0.53
10/24/2025	12:00:00 PM	0.53
10/24/2025	12:15:00 PM	0.53
10/24/2025	12:30:00 PM	0.53
10/24/2025	12:45:00 PM	0.53
10/24/2025	1:00:00 PM	0.53
10/24/2025	1:15:00 PM	0.53
10/24/2025	1:30:00 PM	0.53
10/24/2025	1:45:00 PM	0.53
10/24/2025	2:00:00 PM	0.53
10/24/2025	2:15:00 PM	0.53
10/24/2025	2:30:00 PM	0.53
10/24/2025	2:45:00 PM	0.53
10/24/2025	3:00:00 PM	0.53
10/24/2025	3:15:00 PM	0.53
10/24/2025	3:30:00 PM	0.53
10/24/2025	3:45:00 PM	0.53
10/24/2025	4:00:00 PM	0.53
10/24/2025	4:15:00 PM	0.53
10/24/2025	4:30:00 PM	0.53
10/24/2025	4:45:00 PM	0.53
10/24/2025	5:00:00 PM	0.53
10/24/2025	5:15:00 PM	0.53
10/24/2025	5:30:00 PM	0.53
10/24/2025	5:45:00 PM	0.53
10/24/2025	6:00:00 PM	0.53
10/24/2025	6:15:00 PM	0.53
10/24/2025	6:30:00 PM	0.53
10/24/2025	6:45:00 PM	0.53
10/24/2025	7:00:00 PM	0.53
10/24/2025	7:15:00 PM	0.53
10/24/2025	7:30:00 PM	0.53
10/24/2025	7:45:00 PM	0.53
10/24/2025	8:00:00 PM	0.53
10/24/2025	8:15:00 PM	0.53
10/24/2025	8:30:00 PM	0.53
10/24/2025	8:45:00 PM	0.53
10/24/2025	9:00:00 PM	0.53
10/24/2025	9:15:00 PM	0.53
10/24/2025	9:30:00 PM	0.53
10/24/2025	9:45:00 PM	0.53
10/24/2025	10:00:00 PM	0.53
10/24/2025	10:15:00 PM	0.53
10/24/2025	10:30:00 PM	0.53
10/24/2025	10:45:00 PM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/24/2025	11:00:00 PM	0.53
10/24/2025	11:15:00 PM	0.53
10/24/2025	11:30:00 PM	0.53
10/24/2025	11:45:00 PM	0.53
10/25/2025	12:00:00 AM	0.53
10/25/2025	12:15:00 AM	0.53
10/25/2025	12:30:00 AM	0.53
10/25/2025	12:45:00 AM	0.53
10/25/2025	1:00:00 AM	0.53
10/25/2025	1:15:00 AM	0.53
10/25/2025	1:30:00 AM	0.53
10/25/2025	1:45:00 AM	0.53
10/25/2025	2:00:00 AM	0.53
10/25/2025	2:15:00 AM	0.53
10/25/2025	2:30:00 AM	0.53
10/25/2025	2:45:00 AM	0.53
10/25/2025	3:00:00 AM	0.53
10/25/2025	3:15:00 AM	0.53
10/25/2025	3:30:00 AM	0.53
10/25/2025	3:45:00 AM	0.53
10/25/2025	4:00:00 AM	0.53
10/25/2025	4:15:00 AM	0.53
10/25/2025	4:30:00 AM	0.53
10/25/2025	4:45:00 AM	0.53
10/25/2025	5:00:00 AM	0.53
10/25/2025	5:15:00 AM	0.53
10/25/2025	5:30:00 AM	0.53
10/25/2025	5:45:00 AM	0.53
10/25/2025	6:00:00 AM	0.53
10/25/2025	6:15:00 AM	0.53
10/25/2025	6:30:00 AM	0.53
10/25/2025	6:45:00 AM	0.53
10/25/2025	7:00:00 AM	0.53
10/25/2025	7:15:00 AM	0.53
10/25/2025	7:30:00 AM	0.53
10/25/2025	7:45:00 AM	0.53
10/25/2025	8:00:00 AM	0.53
10/25/2025	8:15:00 AM	0.53
10/25/2025	8:30:00 AM	0.53
10/25/2025	8:45:00 AM	0.53
10/25/2025	9:00:00 AM	0.53
10/25/2025	9:15:00 AM	0.53
10/25/2025	9:30:00 AM	0.53
10/25/2025	9:45:00 AM	0.53
10/25/2025	10:00:00 AM	0.53
10/25/2025	10:15:00 AM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/25/2025	10:30:00 AM	0.53
10/25/2025	10:45:00 AM	0.54
10/25/2025	11:00:00 AM	0.54
10/25/2025	11:15:00 AM	0.54
10/25/2025	11:30:00 AM	0.54
10/25/2025	11:45:00 AM	0.54
10/25/2025	12:00:00 PM	0.54
10/25/2025	12:15:00 PM	0.54
10/25/2025	12:30:00 PM	0.53
10/25/2025	12:45:00 PM	0.54
10/25/2025	1:00:00 PM	0.53
10/25/2025	1:15:00 PM	0.53
10/25/2025	1:30:00 PM	0.53
10/25/2025	1:45:00 PM	0.53
10/25/2025	2:00:00 PM	0.53
10/25/2025	2:15:00 PM	0.53
10/25/2025	2:30:00 PM	0.53
10/25/2025	2:45:00 PM	0.53
10/25/2025	3:00:00 PM	0.53
10/25/2025	3:15:00 PM	0.53
10/25/2025	3:30:00 PM	0.53
10/25/2025	3:45:00 PM	0.53
10/25/2025	4:00:00 PM	0.53
10/25/2025	4:15:00 PM	0.53
10/25/2025	4:30:00 PM	0.53
10/25/2025	4:45:00 PM	0.53
10/25/2025	5:00:00 PM	0.53
10/25/2025	5:15:00 PM	0.53
10/25/2025	5:30:00 PM	0.53
10/25/2025	5:45:00 PM	0.53
10/25/2025	6:00:00 PM	0.53
10/25/2025	6:15:00 PM	0.53
10/25/2025	6:30:00 PM	0.53
10/25/2025	6:45:00 PM	0.53
10/25/2025	7:00:00 PM	0.53
10/25/2025	7:15:00 PM	0.53
10/25/2025	7:30:00 PM	0.53
10/25/2025	7:45:00 PM	0.53
10/25/2025	8:00:00 PM	0.53
10/25/2025	8:15:00 PM	0.53
10/25/2025	8:30:00 PM	0.53
10/25/2025	8:45:00 PM	0.53
10/25/2025	9:00:00 PM	0.53
10/25/2025	9:15:00 PM	0.53
10/25/2025	9:30:00 PM	0.53
10/25/2025	9:45:00 PM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/25/2025	10:00:00 PM	0.53
10/25/2025	10:15:00 PM	0.53
10/25/2025	10:30:00 PM	0.53
10/25/2025	10:45:00 PM	0.53
10/25/2025	11:00:00 PM	0.53
10/25/2025	11:15:00 PM	0.53
10/25/2025	11:30:00 PM	0.53
10/25/2025	11:45:00 PM	0.53
10/26/2025	12:00:00 AM	0.53
10/26/2025	12:15:00 AM	0.53
10/26/2025	12:30:00 AM	0.53
10/26/2025	12:45:00 AM	0.53
10/26/2025	1:00:00 AM	0.53
10/26/2025	1:15:00 AM	0.53
10/26/2025	1:30:00 AM	0.53
10/26/2025	1:45:00 AM	0.53
10/26/2025	2:00:00 AM	0.53
10/26/2025	2:15:00 AM	0.53
10/26/2025	2:30:00 AM	0.53
10/26/2025	2:45:00 AM	0.53
10/26/2025	3:00:00 AM	0.53
10/26/2025	3:15:00 AM	0.53
10/26/2025	3:30:00 AM	0.53
10/26/2025	3:45:00 AM	0.53
10/26/2025	4:00:00 AM	0.53
10/26/2025	4:15:00 AM	0.53
10/26/2025	4:30:00 AM	0.53
10/26/2025	4:45:00 AM	0.53
10/26/2025	5:00:00 AM	0.52
10/26/2025	5:15:00 AM	0.52
10/26/2025	5:30:00 AM	0.52
10/26/2025	5:45:00 AM	0.52
10/26/2025	6:00:00 AM	0.52
10/26/2025	6:15:00 AM	0.52
10/26/2025	6:30:00 AM	0.52
10/26/2025	6:45:00 AM	0.52
10/26/2025	7:00:00 AM	0.52
10/26/2025	7:15:00 AM	0.52
10/26/2025	7:30:00 AM	0.52
10/26/2025	7:45:00 AM	0.52
10/26/2025	8:00:00 AM	0.52
10/26/2025	8:15:00 AM	0.52
10/26/2025	8:30:00 AM	0.52
10/26/2025	8:45:00 AM	0.52
10/26/2025	9:00:00 AM	0.52
10/26/2025	9:15:00 AM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/26/2025	9:30:00 AM	0.52
10/26/2025	9:45:00 AM	0.52
10/26/2025	10:00:00 AM	0.52
10/26/2025	10:15:00 AM	0.52
10/26/2025	10:30:00 AM	0.52
10/26/2025	10:45:00 AM	0.52
10/26/2025	11:00:00 AM	0.52
10/26/2025	11:15:00 AM	0.52
10/26/2025	11:30:00 AM	0.52
10/26/2025	11:45:00 AM	0.52
10/26/2025	12:00:00 PM	0.52
10/26/2025	12:15:00 PM	0.52
10/26/2025	12:30:00 PM	0.52
10/26/2025	12:45:00 PM	0.52
10/26/2025	1:00:00 PM	0.52
10/26/2025	1:15:00 PM	0.52
10/26/2025	1:30:00 PM	0.52
10/26/2025	1:45:00 PM	0.52
10/26/2025	2:00:00 PM	0.52
10/26/2025	2:15:00 PM	0.52
10/26/2025	2:30:00 PM	0.51
10/26/2025	2:45:00 PM	0.51
10/26/2025	3:00:00 PM	0.51
10/26/2025	3:15:00 PM	0.51
10/26/2025	3:30:00 PM	0.51
10/26/2025	3:45:00 PM	0.51
10/26/2025	4:00:00 PM	0.51
10/26/2025	4:15:00 PM	0.51
10/26/2025	4:30:00 PM	0.51
10/26/2025	4:45:00 PM	0.51
10/26/2025	5:00:00 PM	0.51
10/26/2025	5:15:00 PM	0.51
10/26/2025	5:30:00 PM	0.51
10/26/2025	5:45:00 PM	0.51
10/26/2025	6:00:00 PM	0.51
10/26/2025	6:15:00 PM	0.51
10/26/2025	6:30:00 PM	0.51
10/26/2025	6:45:00 PM	0.51
10/26/2025	7:00:00 PM	0.51
10/26/2025	7:15:00 PM	0.51
10/26/2025	7:30:00 PM	0.51
10/26/2025	7:45:00 PM	0.51
10/26/2025	8:00:00 PM	0.51
10/26/2025	8:15:00 PM	0.51
10/26/2025	8:30:00 PM	0.51
10/26/2025	8:45:00 PM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/26/2025	9:00:00 PM	0.51
10/26/2025	9:15:00 PM	0.51
10/26/2025	9:30:00 PM	0.51
10/26/2025	9:45:00 PM	0.51
10/26/2025	10:00:00 PM	0.51
10/26/2025	10:15:00 PM	0.51
10/26/2025	10:30:00 PM	0.51
10/26/2025	10:45:00 PM	0.51
10/26/2025	11:00:00 PM	0.51
10/26/2025	11:15:00 PM	0.51
10/26/2025	11:30:00 PM	0.51
10/26/2025	11:45:00 PM	0.51
10/27/2025	12:00:00 AM	0.51
10/27/2025	12:15:00 AM	0.51
10/27/2025	12:30:00 AM	0.51
10/27/2025	12:45:00 AM	0.51
10/27/2025	1:00:00 AM	0.51
10/27/2025	1:15:00 AM	0.51
10/27/2025	1:30:00 AM	0.51
10/27/2025	1:45:00 AM	0.51
10/27/2025	2:00:00 AM	0.51
10/27/2025	2:15:00 AM	0.51
10/27/2025	2:30:00 AM	0.51
10/27/2025	2:45:00 AM	0.51
10/27/2025	3:00:00 AM	0.51
10/27/2025	3:15:00 AM	0.51
10/27/2025	3:30:00 AM	0.51
10/27/2025	3:45:00 AM	0.51
10/27/2025	4:00:00 AM	0.51
10/27/2025	4:15:00 AM	0.51
10/27/2025	4:30:00 AM	0.52
10/27/2025	4:45:00 AM	0.52
10/27/2025	5:00:00 AM	0.52
10/27/2025	5:15:00 AM	0.52
10/27/2025	5:30:00 AM	0.51
10/27/2025	5:45:00 AM	0.52
10/27/2025	6:00:00 AM	0.52
10/27/2025	6:15:00 AM	0.52
10/27/2025	6:30:00 AM	0.52
10/27/2025	6:45:00 AM	0.52
10/27/2025	7:00:00 AM	0.52
10/27/2025	7:15:00 AM	0.52
10/27/2025	7:30:00 AM	0.52
10/27/2025	7:45:00 AM	0.52
10/27/2025	8:00:00 AM	0.52
10/27/2025	8:15:00 AM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/27/2025	8:30:00 AM	0.52
10/27/2025	8:45:00 AM	0.52
10/27/2025	9:00:00 AM	0.52
10/27/2025	9:15:00 AM	0.52
10/27/2025	9:30:00 AM	0.52
10/27/2025	9:45:00 AM	0.52
10/27/2025	10:00:00 AM	0.52
10/27/2025	10:15:00 AM	0.52
10/27/2025	10:30:00 AM	0.52
10/27/2025	10:45:00 AM	0.52
10/27/2025	11:00:00 AM	0.52
10/27/2025	11:15:00 AM	0.52
10/27/2025	11:30:00 AM	0.52
10/27/2025	11:45:00 AM	0.52
10/27/2025	12:00:00 PM	0.52
10/27/2025	12:15:00 PM	0.52
10/27/2025	12:30:00 PM	0.52
10/27/2025	12:45:00 PM	0.52
10/27/2025	1:00:00 PM	0.52
10/27/2025	1:15:00 PM	0.52
10/27/2025	1:30:00 PM	0.52
10/27/2025	1:45:00 PM	0.52
10/27/2025	2:00:00 PM	0.52
10/27/2025	2:15:00 PM	0.52
10/27/2025	2:30:00 PM	0.52
10/27/2025	2:45:00 PM	0.52
10/27/2025	3:00:00 PM	0.52
10/27/2025	3:15:00 PM	0.52
10/27/2025	3:30:00 PM	0.52
10/27/2025	3:45:00 PM	0.52
10/27/2025	4:00:00 PM	0.52
10/27/2025	4:15:00 PM	0.52
10/27/2025	4:30:00 PM	0.52
10/27/2025	4:45:00 PM	0.52
10/27/2025	5:00:00 PM	0.52
10/27/2025	5:15:00 PM	0.52
10/27/2025	5:30:00 PM	0.52
10/27/2025	5:45:00 PM	0.52
10/27/2025	6:00:00 PM	0.52
10/27/2025	6:15:00 PM	0.52
10/27/2025	6:30:00 PM	0.52
10/27/2025	6:45:00 PM	0.52
10/27/2025	7:00:00 PM	0.52
10/27/2025	7:15:00 PM	0.52
10/27/2025	7:30:00 PM	0.52
10/27/2025	7:45:00 PM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/27/2025	8:00:00 PM	0.52
10/27/2025	8:15:00 PM	0.52
10/27/2025	8:30:00 PM	0.52
10/27/2025	8:45:00 PM	0.52
10/27/2025	9:00:00 PM	0.52
10/27/2025	9:15:00 PM	0.52
10/27/2025	9:30:00 PM	0.52
10/27/2025	9:45:00 PM	0.52
10/27/2025	10:00:00 PM	0.52
10/27/2025	10:15:00 PM	0.52
10/27/2025	10:30:00 PM	0.52
10/27/2025	10:45:00 PM	0.53
10/27/2025	11:00:00 PM	0.53
10/27/2025	11:15:00 PM	0.53
10/27/2025	11:30:00 PM	0.53
10/27/2025	11:45:00 PM	0.53
10/28/2025	12:00:00 AM	0.53
10/28/2025	12:15:00 AM	0.53
10/28/2025	12:30:00 AM	0.53
10/28/2025	12:45:00 AM	0.53
10/28/2025	1:00:00 AM	0.53
10/28/2025	1:15:00 AM	0.53
10/28/2025	1:30:00 AM	0.53
10/28/2025	1:45:00 AM	0.53
10/28/2025	2:00:00 AM	0.53
10/28/2025	2:15:00 AM	0.53
10/28/2025	2:30:00 AM	0.53
10/28/2025	2:45:00 AM	0.53
10/28/2025	3:00:00 AM	0.53
10/28/2025	3:15:00 AM	0.53
10/28/2025	3:30:00 AM	0.53
10/28/2025	3:45:00 AM	0.53
10/28/2025	4:00:00 AM	0.53
10/28/2025	4:15:00 AM	0.54
10/28/2025	4:30:00 AM	0.53
10/28/2025	4:45:00 AM	0.54
10/28/2025	5:00:00 AM	0.53
10/28/2025	5:15:00 AM	0.53
10/28/2025	5:30:00 AM	0.54
10/28/2025	5:45:00 AM	0.54
10/28/2025	6:00:00 AM	0.54
10/28/2025	6:15:00 AM	0.54
10/28/2025	6:30:00 AM	0.54
10/28/2025	6:45:00 AM	0.54
10/28/2025	7:00:00 AM	0.54
10/28/2025	7:15:00 AM	0.54

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/28/2025	7:30:00 AM	0.54
10/28/2025	7:45:00 AM	0.54
10/28/2025	8:00:00 AM	0.54
10/28/2025	8:15:00 AM	0.54
10/28/2025	8:30:00 AM	0.54
10/28/2025	8:45:00 AM	0.54
10/28/2025	9:00:00 AM	0.54
10/28/2025	9:15:00 AM	0.54
10/28/2025	9:30:00 AM	0.54
10/28/2025	9:45:00 AM	0.54
10/28/2025	10:00:00 AM	0.54
10/28/2025	10:15:00 AM	0.54
10/28/2025	10:30:00 AM	0.54
10/28/2025	10:45:00 AM	0.54
10/28/2025	11:00:00 AM	0.54
10/28/2025	11:15:00 AM	0.54
10/28/2025	11:30:00 AM	0.54
10/28/2025	11:45:00 AM	0.54
10/28/2025	12:00:00 PM	0.54
10/28/2025	12:15:00 PM	0.54
10/28/2025	12:30:00 PM	0.54
10/28/2025	12:45:00 PM	0.54
10/28/2025	1:00:00 PM	0.54
10/28/2025	1:15:00 PM	0.54
10/28/2025	1:30:00 PM	0.54
10/28/2025	1:45:00 PM	0.54
10/28/2025	2:00:00 PM	0.54
10/28/2025	2:15:00 PM	0.54
10/28/2025	2:30:00 PM	0.54
10/28/2025	2:45:00 PM	0.54
10/28/2025	3:00:00 PM	0.54
10/28/2025	3:15:00 PM	0.54
10/28/2025	3:30:00 PM	0.54
10/28/2025	3:45:00 PM	0.54
10/28/2025	4:00:00 PM	0.54
10/28/2025	4:15:00 PM	0.54
10/28/2025	4:30:00 PM	0.54
10/28/2025	4:45:00 PM	0.54
10/28/2025	5:00:00 PM	0.54
10/28/2025	5:15:00 PM	0.54
10/28/2025	5:30:00 PM	0.54
10/28/2025	5:45:00 PM	0.54
10/28/2025	6:00:00 PM	0.54
10/28/2025	6:15:00 PM	0.54
10/28/2025	6:30:00 PM	0.54
10/28/2025	6:45:00 PM	0.54

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/28/2025	7:00:00 PM	0.54
10/28/2025	7:15:00 PM	0.54
10/28/2025	7:30:00 PM	0.54
10/28/2025	7:45:00 PM	0.54
10/28/2025	8:00:00 PM	0.54
10/28/2025	8:15:00 PM	0.54
10/28/2025	8:30:00 PM	0.54
10/28/2025	8:45:00 PM	0.54
10/28/2025	9:00:00 PM	0.54
10/28/2025	9:15:00 PM	0.54
10/28/2025	9:30:00 PM	0.54
10/28/2025	9:45:00 PM	0.54
10/28/2025	10:00:00 PM	0.54
10/28/2025	10:15:00 PM	0.54
10/28/2025	10:30:00 PM	0.54
10/28/2025	10:45:00 PM	0.54
10/28/2025	11:00:00 PM	0.54
10/28/2025	11:15:00 PM	0.54
10/28/2025	11:30:00 PM	0.54
10/28/2025	11:45:00 PM	0.54
10/29/2025	12:00:00 AM	0.54
10/29/2025	12:15:00 AM	0.54
10/29/2025	12:30:00 AM	0.54
10/29/2025	12:45:00 AM	0.54
10/29/2025	1:00:00 AM	0.54
10/29/2025	1:15:00 AM	0.54
10/29/2025	1:30:00 AM	0.54
10/29/2025	1:45:00 AM	0.54
10/29/2025	2:00:00 AM	0.54
10/29/2025	2:15:00 AM	0.54
10/29/2025	2:30:00 AM	0.54
10/29/2025	2:45:00 AM	0.54
10/29/2025	3:00:00 AM	0.54
10/29/2025	3:15:00 AM	0.54
10/29/2025	3:30:00 AM	0.54
10/29/2025	3:45:00 AM	0.54
10/29/2025	4:00:00 AM	0.54
10/29/2025	4:15:00 AM	0.54
10/29/2025	4:30:00 AM	0.54
10/29/2025	4:45:00 AM	0.54
10/29/2025	5:00:00 AM	0.54
10/29/2025	5:15:00 AM	0.54
10/29/2025	5:30:00 AM	0.54
10/29/2025	5:45:00 AM	0.54
10/29/2025	6:00:00 AM	0.54
10/29/2025	6:15:00 AM	0.54

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/29/2025	6:30:00 AM	0.54
10/29/2025	6:45:00 AM	0.54
10/29/2025	7:00:00 AM	0.54
10/29/2025	7:15:00 AM	0.54
10/29/2025	7:30:00 AM	0.54
10/29/2025	7:45:00 AM	0.54
10/29/2025	8:00:00 AM	0.54
10/29/2025	8:15:00 AM	0.54
10/29/2025	8:30:00 AM	0.54
10/29/2025	8:45:00 AM	0.54
10/29/2025	9:00:00 AM	0.54
10/29/2025	9:15:00 AM	0.54
10/29/2025	9:30:00 AM	0.54
10/29/2025	9:45:00 AM	0.54
10/29/2025	10:00:00 AM	0.54
10/29/2025	10:15:00 AM	0.54
10/29/2025	10:30:00 AM	0.54
10/29/2025	10:45:00 AM	0.54
10/29/2025	11:00:00 AM	0.54
10/29/2025	11:15:00 AM	0.54
10/29/2025	11:30:00 AM	0.54
10/29/2025	11:45:00 AM	0.54
10/29/2025	12:00:00 PM	0.54
10/29/2025	12:15:00 PM	0.54
10/29/2025	12:30:00 PM	0.54
10/29/2025	12:45:00 PM	0.54
10/29/2025	1:00:00 PM	0.54
10/29/2025	1:15:00 PM	0.54
10/29/2025	1:30:00 PM	0.54
10/29/2025	1:45:00 PM	0.54
10/29/2025	2:00:00 PM	0.54
10/29/2025	2:15:00 PM	0.54
10/29/2025	2:30:00 PM	0.54
10/29/2025	2:45:00 PM	0.54
10/29/2025	3:00:00 PM	0.54
10/29/2025	3:15:00 PM	0.54
10/29/2025	3:30:00 PM	0.54
10/29/2025	3:45:00 PM	0.54
10/29/2025	4:00:00 PM	0.54
10/29/2025	4:15:00 PM	0.54
10/29/2025	4:30:00 PM	0.54
10/29/2025	4:45:00 PM	0.54
10/29/2025	5:00:00 PM	0.54
10/29/2025	5:15:00 PM	0.54
10/29/2025	5:30:00 PM	0.54
10/29/2025	5:45:00 PM	0.54

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/29/2025	6:00:00 PM	0.54
10/29/2025	6:15:00 PM	0.53
10/29/2025	6:30:00 PM	0.54
10/29/2025	6:45:00 PM	0.54
10/29/2025	7:00:00 PM	0.54
10/29/2025	7:15:00 PM	0.54
10/29/2025	7:30:00 PM	0.54
10/29/2025	7:45:00 PM	0.54
10/29/2025	8:00:00 PM	0.54
10/29/2025	8:15:00 PM	0.54
10/29/2025	8:30:00 PM	0.53
10/29/2025	8:45:00 PM	0.54
10/29/2025	9:00:00 PM	0.54
10/29/2025	9:15:00 PM	0.53
10/29/2025	9:30:00 PM	0.53
10/29/2025	9:45:00 PM	0.54
10/29/2025	10:00:00 PM	0.53
10/29/2025	10:15:00 PM	0.53
10/29/2025	10:30:00 PM	0.53
10/29/2025	10:45:00 PM	0.54
10/29/2025	11:00:00 PM	0.53
10/29/2025	11:15:00 PM	0.53
10/29/2025	11:30:00 PM	0.53
10/29/2025	11:45:00 PM	0.53
10/30/2025	12:00:00 AM	0.53
10/30/2025	12:15:00 AM	0.53
10/30/2025	12:30:00 AM	0.53
10/30/2025	12:45:00 AM	0.53
10/30/2025	1:00:00 AM	0.53
10/30/2025	1:15:00 AM	0.53
10/30/2025	1:30:00 AM	0.53
10/30/2025	1:45:00 AM	0.53
10/30/2025	2:00:00 AM	0.53
10/30/2025	2:15:00 AM	0.54
10/30/2025	2:30:00 AM	0.53
10/30/2025	2:45:00 AM	0.53
10/30/2025	3:00:00 AM	0.53
10/30/2025	3:15:00 AM	0.53
10/30/2025	3:30:00 AM	0.53
10/30/2025	3:45:00 AM	0.53
10/30/2025	4:00:00 AM	0.53
10/30/2025	4:15:00 AM	0.53
10/30/2025	4:30:00 AM	0.53
10/30/2025	4:45:00 AM	0.53
10/30/2025	5:00:00 AM	0.53
10/30/2025	5:15:00 AM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/30/2025	5:30:00 AM	0.53
10/30/2025	5:45:00 AM	0.53
10/30/2025	6:00:00 AM	0.53
10/30/2025	6:15:00 AM	0.53
10/30/2025	6:30:00 AM	0.53
10/30/2025	6:45:00 AM	0.53
10/30/2025	7:00:00 AM	0.53
10/30/2025	7:15:00 AM	0.53
10/30/2025	7:30:00 AM	0.53
10/30/2025	7:45:00 AM	0.53
10/30/2025	8:00:00 AM	0.53
10/30/2025	8:15:00 AM	0.53
10/30/2025	8:30:00 AM	0.53
10/30/2025	8:45:00 AM	0.53
10/30/2025	9:00:00 AM	0.53
10/30/2025	9:15:00 AM	0.53
10/30/2025	9:30:00 AM	0.53
10/30/2025	9:45:00 AM	0.53
10/30/2025	10:00:00 AM	0.53
10/30/2025	10:15:00 AM	0.53
10/30/2025	10:30:00 AM	0.53
10/30/2025	10:45:00 AM	0.53
10/30/2025	11:00:00 AM	0.53
10/30/2025	11:15:00 AM	0.53
10/30/2025	11:30:00 AM	0.53
10/30/2025	11:45:00 AM	0.53
10/30/2025	12:00:00 PM	0.53
10/30/2025	12:15:00 PM	0.53
10/30/2025	12:30:00 PM	0.53
10/30/2025	12:45:00 PM	0.53
10/30/2025	1:00:00 PM	0.53
10/30/2025	1:15:00 PM	0.53
10/30/2025	1:30:00 PM	0.53
10/30/2025	1:45:00 PM	0.53
10/30/2025	2:00:00 PM	0.53
10/30/2025	2:15:00 PM	0.53
10/30/2025	2:30:00 PM	0.53
10/30/2025	2:45:00 PM	0.53
10/30/2025	3:00:00 PM	0.53
10/30/2025	3:15:00 PM	0.53
10/30/2025	3:30:00 PM	0.53
10/30/2025	3:45:00 PM	0.53
10/30/2025	4:00:00 PM	0.53
10/30/2025	4:15:00 PM	0.53
10/30/2025	4:30:00 PM	0.53
10/30/2025	4:45:00 PM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/30/2025	5:00:00 PM	0.53
10/30/2025	5:15:00 PM	0.53
10/30/2025	5:30:00 PM	0.53
10/30/2025	5:45:00 PM	0.53
10/30/2025	6:00:00 PM	0.53
10/30/2025	6:15:00 PM	0.53
10/30/2025	6:30:00 PM	0.53
10/30/2025	6:45:00 PM	0.53
10/30/2025	7:00:00 PM	0.53
10/30/2025	7:15:00 PM	0.53
10/30/2025	7:30:00 PM	0.53
10/30/2025	7:45:00 PM	0.53
10/30/2025	8:00:00 PM	0.53
10/30/2025	8:15:00 PM	0.53
10/30/2025	8:30:00 PM	0.53
10/30/2025	8:45:00 PM	0.53
10/30/2025	9:00:00 PM	0.53
10/30/2025	9:15:00 PM	0.53
10/30/2025	9:30:00 PM	0.53
10/30/2025	9:45:00 PM	0.53
10/30/2025	10:00:00 PM	0.53
10/30/2025	10:15:00 PM	0.53
10/30/2025	10:30:00 PM	0.53
10/30/2025	10:45:00 PM	0.53
10/30/2025	11:00:00 PM	0.53
10/30/2025	11:15:00 PM	0.53
10/30/2025	11:30:00 PM	0.53
10/30/2025	11:45:00 PM	0.53
10/31/2025	12:00:00 AM	0.53
10/31/2025	12:15:00 AM	0.53
10/31/2025	12:30:00 AM	0.53
10/31/2025	12:45:00 AM	0.53
10/31/2025	1:00:00 AM	0.53
10/31/2025	1:15:00 AM	0.53
10/31/2025	1:30:00 AM	0.53
10/31/2025	1:45:00 AM	0.53
10/31/2025	2:00:00 AM	0.53
10/31/2025	2:15:00 AM	0.53
10/31/2025	2:30:00 AM	0.53
10/31/2025	2:45:00 AM	0.53
10/31/2025	3:00:00 AM	0.53
10/31/2025	3:15:00 AM	0.53
10/31/2025	3:30:00 AM	0.53
10/31/2025	3:45:00 AM	0.53
10/31/2025	4:00:00 AM	0.53
10/31/2025	4:15:00 AM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/31/2025	4:30:00 AM	0.53
10/31/2025	4:45:00 AM	0.53
10/31/2025	5:00:00 AM	0.53
10/31/2025	5:15:00 AM	0.53
10/31/2025	5:30:00 AM	0.53
10/31/2025	5:45:00 AM	0.53
10/31/2025	6:00:00 AM	0.53
10/31/2025	6:15:00 AM	0.53
10/31/2025	6:30:00 AM	0.53
10/31/2025	6:45:00 AM	0.53
10/31/2025	7:00:00 AM	0.53
10/31/2025	7:15:00 AM	0.53
10/31/2025	7:30:00 AM	0.53
10/31/2025	7:45:00 AM	0.53
10/31/2025	8:00:00 AM	0.53
10/31/2025	8:15:00 AM	0.53
10/31/2025	8:30:00 AM	0.53
10/31/2025	8:45:00 AM	0.53
10/31/2025	9:00:00 AM	0.53
10/31/2025	9:15:00 AM	0.53
10/31/2025	9:30:00 AM	0.53
10/31/2025	9:45:00 AM	0.53
10/31/2025	10:00:00 AM	0.53
10/31/2025	10:15:00 AM	0.53
10/31/2025	10:30:00 AM	0.53
10/31/2025	10:45:00 AM	0.53
10/31/2025	11:00:00 AM	0.53
10/31/2025	11:15:00 AM	0.53
10/31/2025	11:30:00 AM	0.53
10/31/2025	11:45:00 AM	0.53
10/31/2025	12:00:00 PM	0.53
10/31/2025	12:15:00 PM	0.53
10/31/2025	12:30:00 PM	0.53
10/31/2025	12:45:00 PM	0.53
10/31/2025	1:00:00 PM	0.53
10/31/2025	1:15:00 PM	0.53
10/31/2025	1:30:00 PM	0.53
10/31/2025	1:45:00 PM	0.53
10/31/2025	2:00:00 PM	0.53
10/31/2025	2:15:00 PM	0.53
10/31/2025	2:30:00 PM	0.53
10/31/2025	2:45:00 PM	0.53
10/31/2025	3:00:00 PM	0.53
10/31/2025	3:15:00 PM	0.53
10/31/2025	3:30:00 PM	0.53
10/31/2025	3:45:00 PM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
10/31/2025	4:00:00 PM	0.53
10/31/2025	4:15:00 PM	0.53
10/31/2025	4:30:00 PM	0.53
10/31/2025	4:45:00 PM	0.53
10/31/2025	5:00:00 PM	0.53
10/31/2025	5:15:00 PM	0.53
10/31/2025	5:30:00 PM	0.53
10/31/2025	5:45:00 PM	0.53
10/31/2025	6:00:00 PM	0.53
10/31/2025	6:15:00 PM	0.53
10/31/2025	6:30:00 PM	0.53
10/31/2025	6:45:00 PM	0.53
10/31/2025	7:00:00 PM	0.53
10/31/2025	7:15:00 PM	0.53
10/31/2025	7:30:00 PM	0.53
10/31/2025	7:45:00 PM	0.53
10/31/2025	8:00:00 PM	0.53
10/31/2025	8:15:00 PM	0.53
10/31/2025	8:30:00 PM	0.53
10/31/2025	8:45:00 PM	0.53
10/31/2025	9:00:00 PM	0.53
10/31/2025	9:15:00 PM	0.53
10/31/2025	9:30:00 PM	0.53
10/31/2025	9:45:00 PM	0.53
10/31/2025	10:00:00 PM	0.53
10/31/2025	10:15:00 PM	0.53
10/31/2025	10:30:00 PM	0.53
10/31/2025	10:45:00 PM	0.53
10/31/2025	11:00:00 PM	0.53
10/31/2025	11:15:00 PM	0.53
10/31/2025	11:30:00 PM	0.53
10/31/2025	11:45:00 PM	0.53

Billy Lake Return
Station 0213

Date	Flow (cfs)
10/1/2025	1.09
10/2/2025	1.16
10/3/2025	1.17
10/4/2025	1.01
10/5/2025	1.08
10/6/2025	1.50
10/7/2025	1.25
10/8/2025	1.24
10/9/2025	1.21
10/10/2025	1.18
10/11/2025	1.19
10/12/2025	1.06
10/13/2025	1.15
10/14/2025	1.27
10/15/2025	1.30
10/16/2025	1.30
10/17/2025	1.30
10/18/2025	1.30
10/19/2025	1.29
10/20/2025	1.30
10/21/2025	1.30
10/22/2025	1.26
10/23/2025	1.08
10/24/2025	1.24
10/25/2025	1.37
10/26/2025	1.32
10/27/2025	1.30
10/28/2025	1.25
10/29/2025	0.97
10/30/2025	0.83
10/31/2025	1.27

Billy Lake Return Gage

DATE	TIME	GAGE
10/1/2025	12:00:00 AM	0.28
10/1/2025	12:15:00 AM	0.28
10/1/2025	12:30:00 AM	0.28
10/1/2025	12:45:00 AM	0.28
10/1/2025	1:00:00 AM	0.28
10/1/2025	1:15:00 AM	0.28
10/1/2025	1:30:00 AM	0.28
10/1/2025	1:45:00 AM	0.28
10/1/2025	2:00:00 AM	0.28
10/1/2025	2:15:00 AM	0.28
10/1/2025	2:30:00 AM	0.28
10/1/2025	2:45:00 AM	0.28
10/1/2025	3:00:00 AM	0.28
10/1/2025	3:15:00 AM	0.28
10/1/2025	3:30:00 AM	0.28
10/1/2025	3:45:00 AM	0.28
10/1/2025	4:00:00 AM	0.28
10/1/2025	4:15:00 AM	0.28
10/1/2025	4:30:00 AM	0.28
10/1/2025	4:45:00 AM	0.28
10/1/2025	5:00:00 AM	0.28
10/1/2025	5:15:00 AM	0.28
10/1/2025	5:30:00 AM	0.28
10/1/2025	5:45:00 AM	0.28
10/1/2025	6:00:00 AM	0.28
10/1/2025	6:15:00 AM	0.28
10/1/2025	6:30:00 AM	0.28
10/1/2025	6:45:00 AM	0.28
10/1/2025	7:00:00 AM	0.28
10/1/2025	7:15:00 AM	0.28
10/1/2025	7:30:00 AM	0.28
10/1/2025	7:45:00 AM	0.28
10/1/2025	8:00:00 AM	0.28
10/1/2025	8:15:00 AM	0.28
10/1/2025	8:30:00 AM	0.28
10/1/2025	8:45:00 AM	0.27
10/1/2025	9:00:00 AM	0.27
10/1/2025	9:15:00 AM	0.27
10/1/2025	9:30:00 AM	0.27
10/1/2025	9:45:00 AM	0.28
10/1/2025	10:00:00 AM	0.27
10/1/2025	10:15:00 AM	0.27
10/1/2025	10:30:00 AM	0.27
10/1/2025	10:45:00 AM	0.27
10/1/2025	11:00:00 AM	0.27
10/1/2025	11:15:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
10/1/2025	11:30:00 AM	0.27
10/1/2025	11:45:00 AM	0.27
10/1/2025	12:00:00 PM	0.27
10/1/2025	12:15:00 PM	0.27
10/1/2025	12:30:00 PM	0.27
10/1/2025	12:45:00 PM	0.27
10/1/2025	1:00:00 PM	0.27
10/1/2025	1:15:00 PM	0.27
10/1/2025	1:30:00 PM	0.27
10/1/2025	1:45:00 PM	0.27
10/1/2025	2:00:00 PM	0.27
10/1/2025	2:15:00 PM	0.27
10/1/2025	2:30:00 PM	0.27
10/1/2025	2:45:00 PM	0.27
10/1/2025	3:00:00 PM	0.27
10/1/2025	3:15:00 PM	0.27
10/1/2025	3:30:00 PM	0.27
10/1/2025	3:45:00 PM	0.27
10/1/2025	4:00:00 PM	0.27
10/1/2025	4:15:00 PM	0.27
10/1/2025	4:30:00 PM	0.27
10/1/2025	4:45:00 PM	0.27
10/1/2025	5:00:00 PM	0.27
10/1/2025	5:15:00 PM	0.27
10/1/2025	5:30:00 PM	0.27
10/1/2025	5:45:00 PM	0.27
10/1/2025	6:00:00 PM	0.27
10/1/2025	6:15:00 PM	0.27
10/1/2025	6:30:00 PM	0.27
10/1/2025	6:45:00 PM	0.27
10/1/2025	7:00:00 PM	0.28
10/1/2025	7:15:00 PM	0.28
10/1/2025	7:30:00 PM	0.28
10/1/2025	7:45:00 PM	0.28
10/1/2025	8:00:00 PM	0.28
10/1/2025	8:15:00 PM	0.28
10/1/2025	8:30:00 PM	0.28
10/1/2025	8:45:00 PM	0.28
10/1/2025	9:00:00 PM	0.28
10/1/2025	9:15:00 PM	0.28
10/1/2025	9:30:00 PM	0.28
10/1/2025	9:45:00 PM	0.28
10/1/2025	10:00:00 PM	0.28
10/1/2025	10:15:00 PM	0.28
10/1/2025	10:30:00 PM	0.28
10/1/2025	10:45:00 PM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
10/1/2025	11:00:00 PM	0.28
10/1/2025	11:15:00 PM	0.28
10/1/2025	11:30:00 PM	0.28
10/1/2025	11:45:00 PM	0.28
10/2/2025	12:00:00 AM	0.28
10/2/2025	12:15:00 AM	0.28
10/2/2025	12:30:00 AM	0.28
10/2/2025	12:45:00 AM	0.28
10/2/2025	1:00:00 AM	0.28
10/2/2025	1:15:00 AM	0.28
10/2/2025	1:30:00 AM	0.28
10/2/2025	1:45:00 AM	0.28
10/2/2025	2:00:00 AM	0.28
10/2/2025	2:15:00 AM	0.28
10/2/2025	2:30:00 AM	0.28
10/2/2025	2:45:00 AM	0.28
10/2/2025	3:00:00 AM	0.28
10/2/2025	3:15:00 AM	0.28
10/2/2025	3:30:00 AM	0.28
10/2/2025	3:45:00 AM	0.28
10/2/2025	4:00:00 AM	0.28
10/2/2025	4:15:00 AM	0.28
10/2/2025	4:30:00 AM	0.28
10/2/2025	4:45:00 AM	0.28
10/2/2025	5:00:00 AM	0.28
10/2/2025	5:15:00 AM	0.28
10/2/2025	5:30:00 AM	0.28
10/2/2025	5:45:00 AM	0.29
10/2/2025	6:00:00 AM	0.29
10/2/2025	6:15:00 AM	0.29
10/2/2025	6:30:00 AM	0.29
10/2/2025	6:45:00 AM	0.29
10/2/2025	7:00:00 AM	0.29
10/2/2025	7:15:00 AM	0.29
10/2/2025	7:30:00 AM	0.29
10/2/2025	7:45:00 AM	0.29
10/2/2025	8:00:00 AM	0.29
10/2/2025	8:15:00 AM	0.29
10/2/2025	8:30:00 AM	0.29
10/2/2025	8:45:00 AM	0.29
10/2/2025	9:00:00 AM	0.29
10/2/2025	9:15:00 AM	0.29
10/2/2025	9:30:00 AM	0.29
10/2/2025	9:45:00 AM	0.29
10/2/2025	10:00:00 AM	0.29
10/2/2025	10:15:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
10/2/2025	10:30:00 AM	0.29
10/2/2025	10:45:00 AM	0.29
10/2/2025	11:00:00 AM	0.29
10/2/2025	11:15:00 AM	0.29
10/2/2025	11:30:00 AM	0.29
10/2/2025	11:45:00 AM	0.29
10/2/2025	12:00:00 PM	0.29
10/2/2025	12:15:00 PM	0.29
10/2/2025	12:30:00 PM	0.29
10/2/2025	12:45:00 PM	0.29
10/2/2025	1:00:00 PM	0.29
10/2/2025	1:15:00 PM	0.29
10/2/2025	1:30:00 PM	0.29
10/2/2025	1:45:00 PM	0.29
10/2/2025	2:00:00 PM	0.29
10/2/2025	2:15:00 PM	0.29
10/2/2025	2:30:00 PM	0.29
10/2/2025	2:45:00 PM	0.29
10/2/2025	3:00:00 PM	0.29
10/2/2025	3:15:00 PM	0.29
10/2/2025	3:30:00 PM	0.28
10/2/2025	3:45:00 PM	0.29
10/2/2025	4:00:00 PM	0.28
10/2/2025	4:15:00 PM	0.29
10/2/2025	4:30:00 PM	0.29
10/2/2025	4:45:00 PM	0.29
10/2/2025	5:00:00 PM	0.29
10/2/2025	5:15:00 PM	0.28
10/2/2025	5:30:00 PM	0.29
10/2/2025	5:45:00 PM	0.28
10/2/2025	6:00:00 PM	0.29
10/2/2025	6:15:00 PM	0.29
10/2/2025	6:30:00 PM	0.29
10/2/2025	6:45:00 PM	0.29
10/2/2025	7:00:00 PM	0.29
10/2/2025	7:15:00 PM	0.29
10/2/2025	7:30:00 PM	0.29
10/2/2025	7:45:00 PM	0.29
10/2/2025	8:00:00 PM	0.29
10/2/2025	8:15:00 PM	0.29
10/2/2025	8:30:00 PM	0.29
10/2/2025	8:45:00 PM	0.29
10/2/2025	9:00:00 PM	0.29
10/2/2025	9:15:00 PM	0.29
10/2/2025	9:30:00 PM	0.29
10/2/2025	9:45:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
10/2/2025	10:00:00 PM	0.29
10/2/2025	10:15:00 PM	0.29
10/2/2025	10:30:00 PM	0.29
10/2/2025	10:45:00 PM	0.29
10/2/2025	11:00:00 PM	0.29
10/2/2025	11:15:00 PM	0.29
10/2/2025	11:30:00 PM	0.29
10/2/2025	11:45:00 PM	0.29
10/3/2025	12:00:00 AM	0.29
10/3/2025	12:15:00 AM	0.29
10/3/2025	12:30:00 AM	0.29
10/3/2025	12:45:00 AM	0.29
10/3/2025	1:00:00 AM	0.29
10/3/2025	1:15:00 AM	0.29
10/3/2025	1:30:00 AM	0.29
10/3/2025	1:45:00 AM	0.29
10/3/2025	2:00:00 AM	0.29
10/3/2025	2:15:00 AM	0.29
10/3/2025	2:30:00 AM	0.29
10/3/2025	2:45:00 AM	0.29
10/3/2025	3:00:00 AM	0.29
10/3/2025	3:15:00 AM	0.29
10/3/2025	3:30:00 AM	0.29
10/3/2025	3:45:00 AM	0.29
10/3/2025	4:00:00 AM	0.29
10/3/2025	4:15:00 AM	0.29
10/3/2025	4:30:00 AM	0.29
10/3/2025	4:45:00 AM	0.29
10/3/2025	5:00:00 AM	0.29
10/3/2025	5:15:00 AM	0.29
10/3/2025	5:30:00 AM	0.29
10/3/2025	5:45:00 AM	0.29
10/3/2025	6:00:00 AM	0.29
10/3/2025	6:15:00 AM	0.29
10/3/2025	6:30:00 AM	0.29
10/3/2025	6:45:00 AM	0.29
10/3/2025	7:00:00 AM	0.29
10/3/2025	7:15:00 AM	0.29
10/3/2025	7:30:00 AM	0.29
10/3/2025	7:45:00 AM	0.29
10/3/2025	8:00:00 AM	0.29
10/3/2025	8:15:00 AM	0.29
10/3/2025	8:30:00 AM	0.29
10/3/2025	8:45:00 AM	0.29
10/3/2025	9:00:00 AM	0.29
10/3/2025	9:15:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
10/3/2025	9:30:00 AM	0.29
10/3/2025	9:45:00 AM	0.29
10/3/2025	10:00:00 AM	0.29
10/3/2025	10:15:00 AM	0.29
10/3/2025	10:30:00 AM	0.29
10/3/2025	10:45:00 AM	0.29
10/3/2025	11:00:00 AM	0.29
10/3/2025	11:15:00 AM	0.29
10/3/2025	11:30:00 AM	0.29
10/3/2025	11:45:00 AM	0.29
10/3/2025	12:00:00 PM	0.29
10/3/2025	12:15:00 PM	0.29
10/3/2025	12:30:00 PM	0.29
10/3/2025	12:45:00 PM	0.29
10/3/2025	1:00:00 PM	0.29
10/3/2025	1:15:00 PM	0.29
10/3/2025	1:30:00 PM	0.29
10/3/2025	1:45:00 PM	0.29
10/3/2025	2:00:00 PM	0.29
10/3/2025	2:15:00 PM	0.29
10/3/2025	2:30:00 PM	0.29
10/3/2025	2:45:00 PM	0.29
10/3/2025	3:00:00 PM	0.29
10/3/2025	3:15:00 PM	0.29
10/3/2025	3:30:00 PM	0.29
10/3/2025	3:45:00 PM	0.29
10/3/2025	4:00:00 PM	0.29
10/3/2025	4:15:00 PM	0.29
10/3/2025	4:30:00 PM	0.29
10/3/2025	4:45:00 PM	0.29
10/3/2025	5:00:00 PM	0.29
10/3/2025	5:15:00 PM	0.29
10/3/2025	5:30:00 PM	0.29
10/3/2025	5:45:00 PM	0.29
10/3/2025	6:00:00 PM	0.29
10/3/2025	6:15:00 PM	0.29
10/3/2025	6:30:00 PM	0.29
10/3/2025	6:45:00 PM	0.29
10/3/2025	7:00:00 PM	0.29
10/3/2025	7:15:00 PM	0.29
10/3/2025	7:30:00 PM	0.29
10/3/2025	7:45:00 PM	0.29
10/3/2025	8:00:00 PM	0.29
10/3/2025	8:15:00 PM	0.29
10/3/2025	8:30:00 PM	0.29
10/3/2025	8:45:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
10/3/2025	9:00:00 PM	0.29
10/3/2025	9:15:00 PM	0.29
10/3/2025	9:30:00 PM	0.29
10/3/2025	9:45:00 PM	0.29
10/3/2025	10:00:00 PM	0.29
10/3/2025	10:15:00 PM	0.29
10/3/2025	10:30:00 PM	0.29
10/3/2025	10:45:00 PM	0.29
10/3/2025	11:00:00 PM	0.29
10/3/2025	11:15:00 PM	0.29
10/3/2025	11:30:00 PM	0.29
10/3/2025	11:45:00 PM	0.29
10/4/2025	12:00:00 AM	0.29
10/4/2025	12:15:00 AM	0.29
10/4/2025	12:30:00 AM	0.29
10/4/2025	12:45:00 AM	0.29
10/4/2025	1:00:00 AM	0.29
10/4/2025	1:15:00 AM	0.29
10/4/2025	1:30:00 AM	0.29
10/4/2025	1:45:00 AM	0.29
10/4/2025	2:00:00 AM	0.29
10/4/2025	2:15:00 AM	0.29
10/4/2025	2:30:00 AM	0.29
10/4/2025	2:45:00 AM	0.29
10/4/2025	3:00:00 AM	0.29
10/4/2025	3:15:00 AM	0.29
10/4/2025	3:30:00 AM	0.29
10/4/2025	3:45:00 AM	0.29
10/4/2025	4:00:00 AM	0.29
10/4/2025	4:15:00 AM	0.29
10/4/2025	4:30:00 AM	0.29
10/4/2025	4:45:00 AM	0.29
10/4/2025	5:00:00 AM	0.29
10/4/2025	5:15:00 AM	0.29
10/4/2025	5:30:00 AM	0.29
10/4/2025	5:45:00 AM	0.29
10/4/2025	6:00:00 AM	0.29
10/4/2025	6:15:00 AM	0.29
10/4/2025	6:30:00 AM	0.29
10/4/2025	6:45:00 AM	0.29
10/4/2025	7:00:00 AM	0.29
10/4/2025	7:15:00 AM	0.29
10/4/2025	7:30:00 AM	0.29
10/4/2025	7:45:00 AM	0.29
10/4/2025	8:00:00 AM	0.29
10/4/2025	8:15:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
10/4/2025	8:30:00 AM	0.29
10/4/2025	8:45:00 AM	0.29
10/4/2025	9:00:00 AM	0.29
10/4/2025	9:15:00 AM	0.29
10/4/2025	9:30:00 AM	0.29
10/4/2025	9:45:00 AM	0.29
10/4/2025	10:00:00 AM	0.29
10/4/2025	10:15:00 AM	0.29
10/4/2025	10:30:00 AM	0.29
10/4/2025	10:45:00 AM	0.29
10/4/2025	11:00:00 AM	0.29
10/4/2025	11:15:00 AM	0.29
10/4/2025	11:30:00 AM	0.29
10/4/2025	11:45:00 AM	0.29
10/4/2025	12:00:00 PM	0.29
10/4/2025	12:15:00 PM	0.29
10/4/2025	12:30:00 PM	0.29
10/4/2025	12:45:00 PM	0.29
10/4/2025	1:00:00 PM	0.29
10/4/2025	1:15:00 PM	0.29
10/4/2025	1:30:00 PM	0.29
10/4/2025	1:45:00 PM	0.29
10/4/2025	2:00:00 PM	0.29
10/4/2025	2:15:00 PM	0.28
10/4/2025	2:30:00 PM	0.28
10/4/2025	2:45:00 PM	0.27
10/4/2025	3:00:00 PM	0.27
10/4/2025	3:15:00 PM	0.26
10/4/2025	3:30:00 PM	0.26
10/4/2025	3:45:00 PM	0.25
10/4/2025	4:00:00 PM	0.25
10/4/2025	4:15:00 PM	0.25
10/4/2025	4:30:00 PM	0.24
10/4/2025	4:45:00 PM	0.24
10/4/2025	5:00:00 PM	0.24
10/4/2025	5:15:00 PM	0.23
10/4/2025	5:30:00 PM	0.23
10/4/2025	5:45:00 PM	0.23
10/4/2025	6:00:00 PM	0.23
10/4/2025	6:15:00 PM	0.23
10/4/2025	6:30:00 PM	0.22
10/4/2025	6:45:00 PM	0.22
10/4/2025	7:00:00 PM	0.22
10/4/2025	7:15:00 PM	0.21
10/4/2025	7:30:00 PM	0.21
10/4/2025	7:45:00 PM	0.21

Billy Lake Return Gage

DATE	TIME	GAGE
10/4/2025	8:00:00 PM	0.21
10/4/2025	8:15:00 PM	0.21
10/4/2025	8:30:00 PM	0.2
10/4/2025	8:45:00 PM	0.2
10/4/2025	9:00:00 PM	0.2
10/4/2025	9:15:00 PM	0.2
10/4/2025	9:30:00 PM	0.2
10/4/2025	9:45:00 PM	0.2
10/4/2025	10:00:00 PM	0.19
10/4/2025	10:15:00 PM	0.19
10/4/2025	10:30:00 PM	0.19
10/4/2025	10:45:00 PM	0.19
10/4/2025	11:00:00 PM	0.19
10/4/2025	11:15:00 PM	0.19
10/4/2025	11:30:00 PM	0.19
10/4/2025	11:45:00 PM	0.19
10/5/2025	12:00:00 AM	0.19
10/5/2025	12:15:00 AM	0.19
10/5/2025	12:30:00 AM	0.19
10/5/2025	12:45:00 AM	0.19
10/5/2025	1:00:00 AM	0.19
10/5/2025	1:15:00 AM	0.19
10/5/2025	1:30:00 AM	0.19
10/5/2025	1:45:00 AM	0.19
10/5/2025	2:00:00 AM	0.19
10/5/2025	2:15:00 AM	0.19
10/5/2025	2:30:00 AM	0.19
10/5/2025	2:45:00 AM	0.19
10/5/2025	3:00:00 AM	0.19
10/5/2025	3:15:00 AM	0.19
10/5/2025	3:30:00 AM	0.19
10/5/2025	3:45:00 AM	0.19
10/5/2025	4:00:00 AM	0.19
10/5/2025	4:15:00 AM	0.19
10/5/2025	4:30:00 AM	0.19
10/5/2025	4:45:00 AM	0.19
10/5/2025	5:00:00 AM	0.19
10/5/2025	5:15:00 AM	0.19
10/5/2025	5:30:00 AM	0.19
10/5/2025	5:45:00 AM	0.19
10/5/2025	6:00:00 AM	0.19
10/5/2025	6:15:00 AM	0.2
10/5/2025	6:30:00 AM	0.2
10/5/2025	6:45:00 AM	0.21
10/5/2025	7:00:00 AM	0.22
10/5/2025	7:15:00 AM	0.22

Billy Lake Return Gage

DATE	TIME	GAGE
10/5/2025	7:30:00 AM	0.23
10/5/2025	7:45:00 AM	0.23
10/5/2025	8:00:00 AM	0.24
10/5/2025	8:15:00 AM	0.24
10/5/2025	8:30:00 AM	0.25
10/5/2025	8:45:00 AM	0.25
10/5/2025	9:00:00 AM	0.26
10/5/2025	9:15:00 AM	0.26
10/5/2025	9:30:00 AM	0.26
10/5/2025	9:45:00 AM	0.27
10/5/2025	10:00:00 AM	0.27
10/5/2025	10:15:00 AM	0.27
10/5/2025	10:30:00 AM	0.28
10/5/2025	10:45:00 AM	0.28
10/5/2025	11:00:00 AM	0.29
10/5/2025	11:15:00 AM	0.29
10/5/2025	11:30:00 AM	0.29
10/5/2025	11:45:00 AM	0.29
10/5/2025	12:00:00 PM	0.29
10/5/2025	12:15:00 PM	0.29
10/5/2025	12:30:00 PM	0.3
10/5/2025	12:45:00 PM	0.3
10/5/2025	1:00:00 PM	0.3
10/5/2025	1:15:00 PM	0.3
10/5/2025	1:30:00 PM	0.31
10/5/2025	1:45:00 PM	0.31
10/5/2025	2:00:00 PM	0.31
10/5/2025	2:15:00 PM	0.31
10/5/2025	2:30:00 PM	0.31
10/5/2025	2:45:00 PM	0.31
10/5/2025	3:00:00 PM	0.31
10/5/2025	3:15:00 PM	0.32
10/5/2025	3:30:00 PM	0.32
10/5/2025	3:45:00 PM	0.32
10/5/2025	4:00:00 PM	0.32
10/5/2025	4:15:00 PM	0.32
10/5/2025	4:30:00 PM	0.32
10/5/2025	4:45:00 PM	0.32
10/5/2025	5:00:00 PM	0.32
10/5/2025	5:15:00 PM	0.32
10/5/2025	5:30:00 PM	0.32
10/5/2025	5:45:00 PM	0.32
10/5/2025	6:00:00 PM	0.33
10/5/2025	6:15:00 PM	0.33
10/5/2025	6:30:00 PM	0.33
10/5/2025	6:45:00 PM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
10/5/2025	7:00:00 PM	0.33
10/5/2025	7:15:00 PM	0.33
10/5/2025	7:30:00 PM	0.33
10/5/2025	7:45:00 PM	0.33
10/5/2025	8:00:00 PM	0.33
10/5/2025	8:15:00 PM	0.33
10/5/2025	8:30:00 PM	0.33
10/5/2025	8:45:00 PM	0.33
10/5/2025	9:00:00 PM	0.33
10/5/2025	9:15:00 PM	0.33
10/5/2025	9:30:00 PM	0.33
10/5/2025	9:45:00 PM	0.33
10/5/2025	10:00:00 PM	0.33
10/5/2025	10:15:00 PM	0.33
10/5/2025	10:30:00 PM	0.33
10/5/2025	10:45:00 PM	0.33
10/5/2025	11:00:00 PM	0.33
10/5/2025	11:15:00 PM	0.33
10/5/2025	11:30:00 PM	0.33
10/5/2025	11:45:00 PM	0.33
10/6/2025	12:00:00 AM	0.33
10/6/2025	12:15:00 AM	0.33
10/6/2025	12:30:00 AM	0.33
10/6/2025	12:45:00 AM	0.33
10/6/2025	1:00:00 AM	0.33
10/6/2025	1:15:00 AM	0.33
10/6/2025	1:30:00 AM	0.33
10/6/2025	1:45:00 AM	0.33
10/6/2025	2:00:00 AM	0.33
10/6/2025	2:15:00 AM	0.33
10/6/2025	2:30:00 AM	0.33
10/6/2025	2:45:00 AM	0.35
10/6/2025	3:00:00 AM	0.35
10/6/2025	3:15:00 AM	0.34
10/6/2025	3:30:00 AM	0.34
10/6/2025	3:45:00 AM	0.34
10/6/2025	4:00:00 AM	0.33
10/6/2025	4:15:00 AM	0.34
10/6/2025	4:30:00 AM	0.34
10/6/2025	4:45:00 AM	0.34
10/6/2025	5:00:00 AM	0.34
10/6/2025	5:15:00 AM	0.34
10/6/2025	5:30:00 AM	0.34
10/6/2025	5:45:00 AM	0.34
10/6/2025	6:00:00 AM	0.34
10/6/2025	6:15:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
10/6/2025	6:30:00 AM	0.34
10/6/2025	6:45:00 AM	0.34
10/6/2025	7:00:00 AM	0.34
10/6/2025	7:15:00 AM	0.34
10/6/2025	7:30:00 AM	0.34
10/6/2025	7:45:00 AM	0.34
10/6/2025	8:00:00 AM	0.34
10/6/2025	8:15:00 AM	0.33
10/6/2025	8:30:00 AM	0.33
10/6/2025	8:45:00 AM	0.33
10/6/2025	9:00:00 AM	0.34
10/6/2025	9:15:00 AM	0.34
10/6/2025	9:30:00 AM	0.34
10/6/2025	9:45:00 AM	0.34
10/6/2025	10:00:00 AM	0.33
10/6/2025	10:15:00 AM	0.34
10/6/2025	10:30:00 AM	0.34
10/6/2025	10:45:00 AM	0.34
10/6/2025	11:00:00 AM	0.34
10/6/2025	11:15:00 AM	0.34
10/6/2025	11:30:00 AM	0.34
10/6/2025	11:45:00 AM	0.33
10/6/2025	12:00:00 PM	0.33
10/6/2025	12:15:00 PM	0.33
10/6/2025	12:30:00 PM	0.37
10/6/2025	12:45:00 PM	0.39
10/6/2025	1:00:00 PM	0.39
10/6/2025	1:15:00 PM	0.38
10/6/2025	1:30:00 PM	0.38
10/6/2025	1:45:00 PM	0.38
10/6/2025	2:00:00 PM	0.37
10/6/2025	2:15:00 PM	0.37
10/6/2025	2:30:00 PM	0.37
10/6/2025	2:45:00 PM	0.36
10/6/2025	3:00:00 PM	0.36
10/6/2025	3:15:00 PM	0.36
10/6/2025	3:30:00 PM	0.36
10/6/2025	3:45:00 PM	0.35
10/6/2025	4:00:00 PM	0.35
10/6/2025	4:15:00 PM	0.35
10/6/2025	4:30:00 PM	0.34
10/6/2025	4:45:00 PM	0.34
10/6/2025	5:00:00 PM	0.34
10/6/2025	5:15:00 PM	0.34
10/6/2025	5:30:00 PM	0.34
10/6/2025	5:45:00 PM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
10/6/2025	6:00:00 PM	0.33
10/6/2025	6:15:00 PM	0.33
10/6/2025	6:30:00 PM	0.33
10/6/2025	6:45:00 PM	0.33
10/6/2025	7:00:00 PM	0.33
10/6/2025	7:15:00 PM	0.33
10/6/2025	7:30:00 PM	0.33
10/6/2025	7:45:00 PM	0.33
10/6/2025	8:00:00 PM	0.33
10/6/2025	8:15:00 PM	0.33
10/6/2025	8:30:00 PM	0.33
10/6/2025	8:45:00 PM	0.32
10/6/2025	9:00:00 PM	0.32
10/6/2025	9:15:00 PM	0.32
10/6/2025	9:30:00 PM	0.32
10/6/2025	9:45:00 PM	0.32
10/6/2025	10:00:00 PM	0.32
10/6/2025	10:15:00 PM	0.32
10/6/2025	10:30:00 PM	0.32
10/6/2025	10:45:00 PM	0.32
10/6/2025	11:00:00 PM	0.32
10/6/2025	11:15:00 PM	0.32
10/6/2025	11:30:00 PM	0.31
10/6/2025	11:45:00 PM	0.31
10/7/2025	12:00:00 AM	0.31
10/7/2025	12:15:00 AM	0.31
10/7/2025	12:30:00 AM	0.31
10/7/2025	12:45:00 AM	0.31
10/7/2025	1:00:00 AM	0.31
10/7/2025	1:15:00 AM	0.31
10/7/2025	1:30:00 AM	0.31
10/7/2025	1:45:00 AM	0.31
10/7/2025	2:00:00 AM	0.31
10/7/2025	2:15:00 AM	0.31
10/7/2025	2:30:00 AM	0.31
10/7/2025	2:45:00 AM	0.31
10/7/2025	3:00:00 AM	0.31
10/7/2025	3:15:00 AM	0.31
10/7/2025	3:30:00 AM	0.31
10/7/2025	3:45:00 AM	0.31
10/7/2025	4:00:00 AM	0.31
10/7/2025	4:15:00 AM	0.31
10/7/2025	4:30:00 AM	0.31
10/7/2025	4:45:00 AM	0.31
10/7/2025	5:00:00 AM	0.31
10/7/2025	5:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
10/7/2025	5:30:00 AM	0.31
10/7/2025	5:45:00 AM	0.3
10/7/2025	6:00:00 AM	0.3
10/7/2025	6:15:00 AM	0.3
10/7/2025	6:30:00 AM	0.3
10/7/2025	6:45:00 AM	0.3
10/7/2025	7:00:00 AM	0.3
10/7/2025	7:15:00 AM	0.3
10/7/2025	7:30:00 AM	0.3
10/7/2025	7:45:00 AM	0.3
10/7/2025	8:00:00 AM	0.3
10/7/2025	8:15:00 AM	0.3
10/7/2025	8:30:00 AM	0.3
10/7/2025	8:45:00 AM	0.3
10/7/2025	9:00:00 AM	0.3
10/7/2025	9:15:00 AM	0.3
10/7/2025	9:30:00 AM	0.3
10/7/2025	9:45:00 AM	0.3
10/7/2025	10:00:00 AM	0.3
10/7/2025	10:15:00 AM	0.3
10/7/2025	10:30:00 AM	0.3
10/7/2025	10:45:00 AM	0.3
10/7/2025	11:00:00 AM	0.3
10/7/2025	11:15:00 AM	0.3
10/7/2025	11:30:00 AM	0.3
10/7/2025	11:45:00 AM	0.3
10/7/2025	12:00:00 PM	0.3
10/7/2025	12:15:00 PM	0.3
10/7/2025	12:30:00 PM	0.3
10/7/2025	12:45:00 PM	0.3
10/7/2025	1:00:00 PM	0.3
10/7/2025	1:15:00 PM	0.3
10/7/2025	1:30:00 PM	0.3
10/7/2025	1:45:00 PM	0.3
10/7/2025	2:00:00 PM	0.3
10/7/2025	2:15:00 PM	0.3
10/7/2025	2:30:00 PM	0.3
10/7/2025	2:45:00 PM	0.3
10/7/2025	3:00:00 PM	0.3
10/7/2025	3:15:00 PM	0.3
10/7/2025	3:30:00 PM	0.3
10/7/2025	3:45:00 PM	0.3
10/7/2025	4:00:00 PM	0.3
10/7/2025	4:15:00 PM	0.3
10/7/2025	4:30:00 PM	0.3
10/7/2025	4:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
10/7/2025	5:00:00 PM	0.3
10/7/2025	5:15:00 PM	0.3
10/7/2025	5:30:00 PM	0.3
10/7/2025	5:45:00 PM	0.3
10/7/2025	6:00:00 PM	0.3
10/7/2025	6:15:00 PM	0.3
10/7/2025	6:30:00 PM	0.3
10/7/2025	6:45:00 PM	0.3
10/7/2025	7:00:00 PM	0.3
10/7/2025	7:15:00 PM	0.3
10/7/2025	7:30:00 PM	0.3
10/7/2025	7:45:00 PM	0.3
10/7/2025	8:00:00 PM	0.3
10/7/2025	8:15:00 PM	0.3
10/7/2025	8:30:00 PM	0.3
10/7/2025	8:45:00 PM	0.3
10/7/2025	9:00:00 PM	0.3
10/7/2025	9:15:00 PM	0.3
10/7/2025	9:30:00 PM	0.3
10/7/2025	9:45:00 PM	0.3
10/7/2025	10:00:00 PM	0.3
10/7/2025	10:15:00 PM	0.3
10/7/2025	10:30:00 PM	0.3
10/7/2025	10:45:00 PM	0.3
10/7/2025	11:00:00 PM	0.3
10/7/2025	11:15:00 PM	0.3
10/7/2025	11:30:00 PM	0.3
10/7/2025	11:45:00 PM	0.3
10/8/2025	12:00:00 AM	0.3
10/8/2025	12:15:00 AM	0.3
10/8/2025	12:30:00 AM	0.3
10/8/2025	12:45:00 AM	0.3
10/8/2025	1:00:00 AM	0.3
10/8/2025	1:15:00 AM	0.3
10/8/2025	1:30:00 AM	0.3
10/8/2025	1:45:00 AM	0.3
10/8/2025	2:00:00 AM	0.3
10/8/2025	2:15:00 AM	0.3
10/8/2025	2:30:00 AM	0.3
10/8/2025	2:45:00 AM	0.3
10/8/2025	3:00:00 AM	0.3
10/8/2025	3:15:00 AM	0.3
10/8/2025	3:30:00 AM	0.3
10/8/2025	3:45:00 AM	0.3
10/8/2025	4:00:00 AM	0.3
10/8/2025	4:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
10/8/2025	4:30:00 AM	0.3
10/8/2025	4:45:00 AM	0.3
10/8/2025	5:00:00 AM	0.3
10/8/2025	5:15:00 AM	0.3
10/8/2025	5:30:00 AM	0.3
10/8/2025	5:45:00 AM	0.3
10/8/2025	6:00:00 AM	0.3
10/8/2025	6:15:00 AM	0.3
10/8/2025	6:30:00 AM	0.3
10/8/2025	6:45:00 AM	.
10/8/2025	7:00:00 AM	.
10/8/2025	7:15:00 AM	.
10/8/2025	7:30:00 AM	.
10/8/2025	7:45:00 AM	.
10/8/2025	8:00:00 AM	0.3
10/8/2025	8:15:00 AM	0.3
10/8/2025	8:30:00 AM	0.3
10/8/2025	8:45:00 AM	0.3
10/8/2025	9:00:00 AM	0.3
10/8/2025	9:15:00 AM	0.3
10/8/2025	9:30:00 AM	0.3
10/8/2025	9:45:00 AM	0.3
10/8/2025	10:00:00 AM	0.3
10/8/2025	10:15:00 AM	0.3
10/8/2025	10:30:00 AM	0.3
10/8/2025	10:45:00 AM	0.3
10/8/2025	11:00:00 AM	0.3
10/8/2025	11:15:00 AM	0.3
10/8/2025	11:30:00 AM	0.3
10/8/2025	11:45:00 AM	0.3
10/8/2025	12:00:00 PM	0.3
10/8/2025	12:15:00 PM	0.3
10/8/2025	12:30:00 PM	0.3
10/8/2025	12:45:00 PM	0.3
10/8/2025	1:00:00 PM	0.3
10/8/2025	1:15:00 PM	0.3
10/8/2025	1:30:00 PM	0.3
10/8/2025	1:45:00 PM	0.3
10/8/2025	2:00:00 PM	0.3
10/8/2025	2:15:00 PM	0.3
10/8/2025	2:30:00 PM	0.3
10/8/2025	2:45:00 PM	0.3
10/8/2025	3:00:00 PM	0.3
10/8/2025	3:15:00 PM	0.3
10/8/2025	3:30:00 PM	0.3
10/8/2025	3:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
10/8/2025	4:00:00 PM	0.3
10/8/2025	4:15:00 PM	0.3
10/8/2025	4:30:00 PM	0.3
10/8/2025	4:45:00 PM	0.3
10/8/2025	5:00:00 PM	0.3
10/8/2025	5:15:00 PM	0.3
10/8/2025	5:30:00 PM	0.29
10/8/2025	5:45:00 PM	0.3
10/8/2025	6:00:00 PM	0.3
10/8/2025	6:15:00 PM	0.3
10/8/2025	6:30:00 PM	0.3
10/8/2025	6:45:00 PM	0.3
10/8/2025	7:00:00 PM	0.3
10/8/2025	7:15:00 PM	0.3
10/8/2025	7:30:00 PM	0.3
10/8/2025	7:45:00 PM	0.3
10/8/2025	8:00:00 PM	0.3
10/8/2025	8:15:00 PM	0.3
10/8/2025	8:30:00 PM	0.3
10/8/2025	8:45:00 PM	0.3
10/8/2025	9:00:00 PM	0.3
10/8/2025	9:15:00 PM	0.3
10/8/2025	9:30:00 PM	0.3
10/8/2025	9:45:00 PM	0.3
10/8/2025	10:00:00 PM	0.3
10/8/2025	10:15:00 PM	0.3
10/8/2025	10:30:00 PM	0.3
10/8/2025	10:45:00 PM	0.3
10/8/2025	11:00:00 PM	0.3
10/8/2025	11:15:00 PM	0.3
10/8/2025	11:30:00 PM	0.3
10/8/2025	11:45:00 PM	0.3
10/9/2025	12:00:00 AM	0.3
10/9/2025	12:15:00 AM	0.3
10/9/2025	12:30:00 AM	0.3
10/9/2025	12:45:00 AM	0.3
10/9/2025	1:00:00 AM	0.3
10/9/2025	1:15:00 AM	0.3
10/9/2025	1:30:00 AM	0.3
10/9/2025	1:45:00 AM	0.3
10/9/2025	2:00:00 AM	0.3
10/9/2025	2:15:00 AM	0.3
10/9/2025	2:30:00 AM	0.3
10/9/2025	2:45:00 AM	0.3
10/9/2025	3:00:00 AM	0.31
10/9/2025	3:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
10/9/2025	3:30:00 AM	0.3
10/9/2025	3:45:00 AM	0.3
10/9/2025	4:00:00 AM	0.3
10/9/2025	4:15:00 AM	0.3
10/9/2025	4:30:00 AM	0.3
10/9/2025	4:45:00 AM	0.3
10/9/2025	5:00:00 AM	0.3
10/9/2025	5:15:00 AM	0.3
10/9/2025	5:30:00 AM	0.3
10/9/2025	5:45:00 AM	0.3
10/9/2025	6:00:00 AM	0.3
10/9/2025	6:15:00 AM	0.3
10/9/2025	6:30:00 AM	0.3
10/9/2025	6:45:00 AM	0.3
10/9/2025	7:00:00 AM	0.3
10/9/2025	7:15:00 AM	0.3
10/9/2025	7:30:00 AM	0.3
10/9/2025	7:45:00 AM	0.3
10/9/2025	8:00:00 AM	0.3
10/9/2025	8:15:00 AM	0.3
10/9/2025	8:30:00 AM	0.3
10/9/2025	8:45:00 AM	0.3
10/9/2025	9:00:00 AM	0.3
10/9/2025	9:15:00 AM	0.3
10/9/2025	9:30:00 AM	0.3
10/9/2025	9:45:00 AM	0.3
10/9/2025	10:00:00 AM	0.3
10/9/2025	10:15:00 AM	0.3
10/9/2025	10:30:00 AM	0.3
10/9/2025	10:45:00 AM	0.3
10/9/2025	11:00:00 AM	0.3
10/9/2025	11:15:00 AM	0.3
10/9/2025	11:30:00 AM	0.3
10/9/2025	11:45:00 AM	0.3
10/9/2025	12:00:00 PM	0.3
10/9/2025	12:15:00 PM	0.3
10/9/2025	12:30:00 PM	0.3
10/9/2025	12:45:00 PM	0.3
10/9/2025	1:00:00 PM	0.3
10/9/2025	1:15:00 PM	0.3
10/9/2025	1:30:00 PM	0.29
10/9/2025	1:45:00 PM	0.29
10/9/2025	2:00:00 PM	0.29
10/9/2025	2:15:00 PM	0.29
10/9/2025	2:30:00 PM	0.29
10/9/2025	2:45:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
10/9/2025	3:00:00 PM	0.29
10/9/2025	3:15:00 PM	0.29
10/9/2025	3:30:00 PM	0.29
10/9/2025	3:45:00 PM	0.29
10/9/2025	4:00:00 PM	0.29
10/9/2025	4:15:00 PM	0.29
10/9/2025	4:30:00 PM	0.29
10/9/2025	4:45:00 PM	0.29
10/9/2025	5:00:00 PM	0.29
10/9/2025	5:15:00 PM	0.29
10/9/2025	5:30:00 PM	0.29
10/9/2025	5:45:00 PM	0.29
10/9/2025	6:00:00 PM	0.29
10/9/2025	6:15:00 PM	0.29
10/9/2025	6:30:00 PM	0.29
10/9/2025	6:45:00 PM	0.29
10/9/2025	7:00:00 PM	0.29
10/9/2025	7:15:00 PM	0.29
10/9/2025	7:30:00 PM	0.29
10/9/2025	7:45:00 PM	0.29
10/9/2025	8:00:00 PM	0.29
10/9/2025	8:15:00 PM	0.29
10/9/2025	8:30:00 PM	0.29
10/9/2025	8:45:00 PM	0.29
10/9/2025	9:00:00 PM	0.29
10/9/2025	9:15:00 PM	0.29
10/9/2025	9:30:00 PM	0.29
10/9/2025	9:45:00 PM	0.29
10/9/2025	10:00:00 PM	0.29
10/9/2025	10:15:00 PM	0.29
10/9/2025	10:30:00 PM	0.29
10/9/2025	10:45:00 PM	0.29
10/9/2025	11:00:00 PM	0.29
10/9/2025	11:15:00 PM	0.29
10/9/2025	11:30:00 PM	0.29
10/9/2025	11:45:00 PM	0.29
10/10/2025	12:00:00 AM	0.29
10/10/2025	12:15:00 AM	0.29
10/10/2025	12:30:00 AM	0.29
10/10/2025	12:45:00 AM	0.29
10/10/2025	1:00:00 AM	0.29
10/10/2025	1:15:00 AM	0.29
10/10/2025	1:30:00 AM	0.29
10/10/2025	1:45:00 AM	0.29
10/10/2025	2:00:00 AM	0.29
10/10/2025	2:15:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
10/10/2025	2:30:00 AM	0.3
10/10/2025	2:45:00 AM	0.29
10/10/2025	3:00:00 AM	0.29
10/10/2025	3:15:00 AM	0.29
10/10/2025	3:30:00 AM	0.29
10/10/2025	3:45:00 AM	0.29
10/10/2025	4:00:00 AM	0.29
10/10/2025	4:15:00 AM	0.29
10/10/2025	4:30:00 AM	0.29
10/10/2025	4:45:00 AM	0.29
10/10/2025	5:00:00 AM	0.29
10/10/2025	5:15:00 AM	0.29
10/10/2025	5:30:00 AM	0.29
10/10/2025	5:45:00 AM	0.29
10/10/2025	6:00:00 AM	0.3
10/10/2025	6:15:00 AM	0.29
10/10/2025	6:30:00 AM	0.29
10/10/2025	6:45:00 AM	0.29
10/10/2025	7:00:00 AM	0.29
10/10/2025	7:15:00 AM	0.29
10/10/2025	7:30:00 AM	0.29
10/10/2025	7:45:00 AM	0.29
10/10/2025	8:00:00 AM	0.3
10/10/2025	8:15:00 AM	0.29
10/10/2025	8:30:00 AM	0.29
10/10/2025	8:45:00 AM	0.29
10/10/2025	9:00:00 AM	0.29
10/10/2025	9:15:00 AM	0.29
10/10/2025	9:30:00 AM	0.29
10/10/2025	9:45:00 AM	0.29
10/10/2025	10:00:00 AM	0.29
10/10/2025	10:15:00 AM	0.29
10/10/2025	10:30:00 AM	0.29
10/10/2025	10:45:00 AM	0.29
10/10/2025	11:00:00 AM	0.29
10/10/2025	11:15:00 AM	0.29
10/10/2025	11:30:00 AM	0.29
10/10/2025	11:45:00 AM	0.29
10/10/2025	12:00:00 PM	0.29
10/10/2025	12:15:00 PM	0.29
10/10/2025	12:30:00 PM	0.29
10/10/2025	12:45:00 PM	0.29
10/10/2025	1:00:00 PM	0.29
10/10/2025	1:15:00 PM	0.29
10/10/2025	1:30:00 PM	0.29
10/10/2025	1:45:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
10/10/2025	2:00:00 PM	0.29
10/10/2025	2:15:00 PM	0.29
10/10/2025	2:30:00 PM	0.29
10/10/2025	2:45:00 PM	0.29
10/10/2025	3:00:00 PM	0.29
10/10/2025	3:15:00 PM	0.29
10/10/2025	3:30:00 PM	0.29
10/10/2025	3:45:00 PM	0.29
10/10/2025	4:00:00 PM	0.29
10/10/2025	4:15:00 PM	0.29
10/10/2025	4:30:00 PM	0.29
10/10/2025	4:45:00 PM	0.29
10/10/2025	5:00:00 PM	0.29
10/10/2025	5:15:00 PM	0.29
10/10/2025	5:30:00 PM	0.29
10/10/2025	5:45:00 PM	0.29
10/10/2025	6:00:00 PM	0.29
10/10/2025	6:15:00 PM	0.29
10/10/2025	6:30:00 PM	0.29
10/10/2025	6:45:00 PM	0.29
10/10/2025	7:00:00 PM	0.29
10/10/2025	7:15:00 PM	0.29
10/10/2025	7:30:00 PM	0.29
10/10/2025	7:45:00 PM	0.29
10/10/2025	8:00:00 PM	0.29
10/10/2025	8:15:00 PM	0.29
10/10/2025	8:30:00 PM	0.29
10/10/2025	8:45:00 PM	0.29
10/10/2025	9:00:00 PM	0.29
10/10/2025	9:15:00 PM	0.29
10/10/2025	9:30:00 PM	0.29
10/10/2025	9:45:00 PM	0.29
10/10/2025	10:00:00 PM	0.29
10/10/2025	10:15:00 PM	0.29
10/10/2025	10:30:00 PM	0.29
10/10/2025	10:45:00 PM	0.29
10/10/2025	11:00:00 PM	0.29
10/10/2025	11:15:00 PM	0.29
10/10/2025	11:30:00 PM	0.29
10/10/2025	11:45:00 PM	0.29
10/11/2025	12:00:00 AM	0.29
10/11/2025	12:15:00 AM	0.29
10/11/2025	12:30:00 AM	0.29
10/11/2025	12:45:00 AM	0.29
10/11/2025	1:00:00 AM	0.29
10/11/2025	1:15:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
10/11/2025	1:30:00 AM	0.29
10/11/2025	1:45:00 AM	0.29
10/11/2025	2:00:00 AM	0.29
10/11/2025	2:15:00 AM	0.29
10/11/2025	2:30:00 AM	0.29
10/11/2025	2:45:00 AM	0.29
10/11/2025	3:00:00 AM	0.29
10/11/2025	3:15:00 AM	0.29
10/11/2025	3:30:00 AM	0.29
10/11/2025	3:45:00 AM	0.29
10/11/2025	4:00:00 AM	0.29
10/11/2025	4:15:00 AM	0.29
10/11/2025	4:30:00 AM	0.29
10/11/2025	4:45:00 AM	0.29
10/11/2025	5:00:00 AM	0.29
10/11/2025	5:15:00 AM	0.3
10/11/2025	5:30:00 AM	0.29
10/11/2025	5:45:00 AM	0.3
10/11/2025	6:00:00 AM	0.29
10/11/2025	6:15:00 AM	0.29
10/11/2025	6:30:00 AM	0.3
10/11/2025	6:45:00 AM	0.3
10/11/2025	7:00:00 AM	0.3
10/11/2025	7:15:00 AM	0.29
10/11/2025	7:30:00 AM	0.3
10/11/2025	7:45:00 AM	0.3
10/11/2025	8:00:00 AM	0.29
10/11/2025	8:15:00 AM	0.29
10/11/2025	8:30:00 AM	0.3
10/11/2025	8:45:00 AM	0.3
10/11/2025	9:00:00 AM	0.29
10/11/2025	9:15:00 AM	0.3
10/11/2025	9:30:00 AM	0.3
10/11/2025	9:45:00 AM	0.3
10/11/2025	10:00:00 AM	0.3
10/11/2025	10:15:00 AM	0.29
10/11/2025	10:30:00 AM	0.3
10/11/2025	10:45:00 AM	0.3
10/11/2025	11:00:00 AM	0.29
10/11/2025	11:15:00 AM	0.3
10/11/2025	11:30:00 AM	0.3
10/11/2025	11:45:00 AM	0.29
10/11/2025	12:00:00 PM	0.3
10/11/2025	12:15:00 PM	0.29
10/11/2025	12:30:00 PM	0.3
10/11/2025	12:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
10/11/2025	1:00:00 PM	0.3
10/11/2025	1:15:00 PM	0.29
10/11/2025	1:30:00 PM	0.29
10/11/2025	1:45:00 PM	0.3
10/11/2025	2:00:00 PM	0.3
10/11/2025	2:15:00 PM	0.29
10/11/2025	2:30:00 PM	0.29
10/11/2025	2:45:00 PM	0.29
10/11/2025	3:00:00 PM	0.29
10/11/2025	3:15:00 PM	0.29
10/11/2025	3:30:00 PM	0.29
10/11/2025	3:45:00 PM	0.29
10/11/2025	4:00:00 PM	0.29
10/11/2025	4:15:00 PM	0.29
10/11/2025	4:30:00 PM	0.29
10/11/2025	4:45:00 PM	0.29
10/11/2025	5:00:00 PM	0.29
10/11/2025	5:15:00 PM	0.29
10/11/2025	5:30:00 PM	0.29
10/11/2025	5:45:00 PM	0.29
10/11/2025	6:00:00 PM	0.29
10/11/2025	6:15:00 PM	0.29
10/11/2025	6:30:00 PM	0.29
10/11/2025	6:45:00 PM	0.29
10/11/2025	7:00:00 PM	0.29
10/11/2025	7:15:00 PM	0.29
10/11/2025	7:30:00 PM	0.29
10/11/2025	7:45:00 PM	0.29
10/11/2025	8:00:00 PM	0.29
10/11/2025	8:15:00 PM	0.29
10/11/2025	8:30:00 PM	0.29
10/11/2025	8:45:00 PM	0.29
10/11/2025	9:00:00 PM	0.29
10/11/2025	9:15:00 PM	0.29
10/11/2025	9:30:00 PM	0.29
10/11/2025	9:45:00 PM	0.29
10/11/2025	10:00:00 PM	0.29
10/11/2025	10:15:00 PM	0.28
10/11/2025	10:30:00 PM	0.28
10/11/2025	10:45:00 PM	0.28
10/11/2025	11:00:00 PM	0.28
10/11/2025	11:15:00 PM	0.28
10/11/2025	11:30:00 PM	0.28
10/11/2025	11:45:00 PM	0.28
10/12/2025	12:00:00 AM	0.28
10/12/2025	12:15:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
10/12/2025	12:30:00 AM	0.28
10/12/2025	12:45:00 AM	0.28
10/12/2025	1:00:00 AM	0.28
10/12/2025	1:15:00 AM	0.28
10/12/2025	1:30:00 AM	0.28
10/12/2025	1:45:00 AM	0.28
10/12/2025	2:00:00 AM	0.28
10/12/2025	2:15:00 AM	0.28
10/12/2025	2:30:00 AM	0.27
10/12/2025	2:45:00 AM	0.28
10/12/2025	3:00:00 AM	0.27
10/12/2025	3:15:00 AM	0.27
10/12/2025	3:30:00 AM	0.27
10/12/2025	3:45:00 AM	0.27
10/12/2025	4:00:00 AM	0.27
10/12/2025	4:15:00 AM	0.27
10/12/2025	4:30:00 AM	0.27
10/12/2025	4:45:00 AM	0.27
10/12/2025	5:00:00 AM	0.27
10/12/2025	5:15:00 AM	0.27
10/12/2025	5:30:00 AM	0.27
10/12/2025	5:45:00 AM	0.27
10/12/2025	6:00:00 AM	0.27
10/12/2025	6:15:00 AM	0.27
10/12/2025	6:30:00 AM	0.27
10/12/2025	6:45:00 AM	0.27
10/12/2025	7:00:00 AM	0.27
10/12/2025	7:15:00 AM	0.27
10/12/2025	7:30:00 AM	0.27
10/12/2025	7:45:00 AM	0.27
10/12/2025	8:00:00 AM	0.27
10/12/2025	8:15:00 AM	0.27
10/12/2025	8:30:00 AM	0.27
10/12/2025	8:45:00 AM	0.27
10/12/2025	9:00:00 AM	0.27
10/12/2025	9:15:00 AM	0.27
10/12/2025	9:30:00 AM	0.27
10/12/2025	9:45:00 AM	0.27
10/12/2025	10:00:00 AM	0.27
10/12/2025	10:15:00 AM	0.27
10/12/2025	10:30:00 AM	0.27
10/12/2025	10:45:00 AM	0.27
10/12/2025	11:00:00 AM	0.27
10/12/2025	11:15:00 AM	0.27
10/12/2025	11:30:00 AM	0.27
10/12/2025	11:45:00 AM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
10/12/2025	12:00:00 PM	0.27
10/12/2025	12:15:00 PM	0.27
10/12/2025	12:30:00 PM	0.27
10/12/2025	12:45:00 PM	0.27
10/12/2025	1:00:00 PM	0.27
10/12/2025	1:15:00 PM	0.27
10/12/2025	1:30:00 PM	0.27
10/12/2025	1:45:00 PM	0.27
10/12/2025	2:00:00 PM	0.27
10/12/2025	2:15:00 PM	0.27
10/12/2025	2:30:00 PM	0.27
10/12/2025	2:45:00 PM	0.27
10/12/2025	3:00:00 PM	0.27
10/12/2025	3:15:00 PM	0.27
10/12/2025	3:30:00 PM	0.27
10/12/2025	3:45:00 PM	0.27
10/12/2025	4:00:00 PM	0.27
10/12/2025	4:15:00 PM	0.27
10/12/2025	4:30:00 PM	0.27
10/12/2025	4:45:00 PM	0.27
10/12/2025	5:00:00 PM	0.27
10/12/2025	5:15:00 PM	0.27
10/12/2025	5:30:00 PM	0.27
10/12/2025	5:45:00 PM	0.27
10/12/2025	6:00:00 PM	0.27
10/12/2025	6:15:00 PM	0.27
10/12/2025	6:30:00 PM	0.27
10/12/2025	6:45:00 PM	0.27
10/12/2025	7:00:00 PM	0.27
10/12/2025	7:15:00 PM	0.27
10/12/2025	7:30:00 PM	0.27
10/12/2025	7:45:00 PM	0.27
10/12/2025	8:00:00 PM	0.27
10/12/2025	8:15:00 PM	0.27
10/12/2025	8:30:00 PM	0.27
10/12/2025	8:45:00 PM	0.27
10/12/2025	9:00:00 PM	0.27
10/12/2025	9:15:00 PM	0.27
10/12/2025	9:30:00 PM	0.27
10/12/2025	9:45:00 PM	0.27
10/12/2025	10:00:00 PM	0.27
10/12/2025	10:15:00 PM	0.27
10/12/2025	10:30:00 PM	0.27
10/12/2025	10:45:00 PM	0.27
10/12/2025	11:00:00 PM	0.27
10/12/2025	11:15:00 PM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
10/12/2025	11:30:00 PM	0.27
10/12/2025	11:45:00 PM	0.27
10/13/2025	12:00:00 AM	0.27
10/13/2025	12:15:00 AM	0.27
10/13/2025	12:30:00 AM	0.27
10/13/2025	12:45:00 AM	0.27
10/13/2025	1:00:00 AM	0.27
10/13/2025	1:15:00 AM	0.27
10/13/2025	1:30:00 AM	0.27
10/13/2025	1:45:00 AM	0.27
10/13/2025	2:00:00 AM	0.27
10/13/2025	2:15:00 AM	0.27
10/13/2025	2:30:00 AM	0.27
10/13/2025	2:45:00 AM	0.27
10/13/2025	3:00:00 AM	0.27
10/13/2025	3:15:00 AM	0.27
10/13/2025	3:30:00 AM	0.27
10/13/2025	3:45:00 AM	0.27
10/13/2025	4:00:00 AM	0.27
10/13/2025	4:15:00 AM	0.27
10/13/2025	4:30:00 AM	0.27
10/13/2025	4:45:00 AM	0.27
10/13/2025	5:00:00 AM	0.27
10/13/2025	5:15:00 AM	0.27
10/13/2025	5:30:00 AM	0.27
10/13/2025	5:45:00 AM	0.27
10/13/2025	6:00:00 AM	0.27
10/13/2025	6:15:00 AM	0.27
10/13/2025	6:30:00 AM	0.27
10/13/2025	6:45:00 AM	0.27
10/13/2025	7:00:00 AM	0.27
10/13/2025	7:15:00 AM	0.27
10/13/2025	7:30:00 AM	0.27
10/13/2025	7:45:00 AM	0.27
10/13/2025	8:00:00 AM	0.28
10/13/2025	8:15:00 AM	0.28
10/13/2025	8:30:00 AM	0.28
10/13/2025	8:45:00 AM	0.28
10/13/2025	9:00:00 AM	0.28
10/13/2025	9:15:00 AM	0.28
10/13/2025	9:30:00 AM	0.28
10/13/2025	9:45:00 AM	0.28
10/13/2025	10:00:00 AM	0.29
10/13/2025	10:15:00 AM	0.29
10/13/2025	10:30:00 AM	0.29
10/13/2025	10:45:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
10/13/2025	11:00:00 AM	0.29
10/13/2025	11:15:00 AM	0.29
10/13/2025	11:30:00 AM	0.29
10/13/2025	11:45:00 AM	0.29
10/13/2025	12:00:00 PM	0.29
10/13/2025	12:15:00 PM	0.29
10/13/2025	12:30:00 PM	0.29
10/13/2025	12:45:00 PM	0.29
10/13/2025	1:00:00 PM	0.29
10/13/2025	1:15:00 PM	0.29
10/13/2025	1:30:00 PM	0.29
10/13/2025	1:45:00 PM	0.29
10/13/2025	2:00:00 PM	0.29
10/13/2025	2:15:00 PM	0.29
10/13/2025	2:30:00 PM	0.29
10/13/2025	2:45:00 PM	0.29
10/13/2025	3:00:00 PM	0.29
10/13/2025	3:15:00 PM	0.29
10/13/2025	3:30:00 PM	0.29
10/13/2025	3:45:00 PM	0.29
10/13/2025	4:00:00 PM	0.29
10/13/2025	4:15:00 PM	0.3
10/13/2025	4:30:00 PM	0.3
10/13/2025	4:45:00 PM	0.3
10/13/2025	5:00:00 PM	0.3
10/13/2025	5:15:00 PM	0.3
10/13/2025	5:30:00 PM	0.3
10/13/2025	5:45:00 PM	0.3
10/13/2025	6:00:00 PM	0.3
10/13/2025	6:15:00 PM	0.3
10/13/2025	6:30:00 PM	0.3
10/13/2025	6:45:00 PM	0.3
10/13/2025	7:00:00 PM	0.3
10/13/2025	7:15:00 PM	0.3
10/13/2025	7:30:00 PM	0.3
10/13/2025	7:45:00 PM	0.3
10/13/2025	8:00:00 PM	0.3
10/13/2025	8:15:00 PM	0.3
10/13/2025	8:30:00 PM	0.3
10/13/2025	8:45:00 PM	0.3
10/13/2025	9:00:00 PM	0.3
10/13/2025	9:15:00 PM	0.3
10/13/2025	9:30:00 PM	0.3
10/13/2025	9:45:00 PM	0.3
10/13/2025	10:00:00 PM	0.3
10/13/2025	10:15:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
10/13/2025	10:30:00 PM	0.3
10/13/2025	10:45:00 PM	0.3
10/13/2025	11:00:00 PM	0.3
10/13/2025	11:15:00 PM	0.3
10/13/2025	11:30:00 PM	0.3
10/13/2025	11:45:00 PM	0.3
10/14/2025	12:00:00 AM	0.3
10/14/2025	12:15:00 AM	0.3
10/14/2025	12:30:00 AM	0.3
10/14/2025	12:45:00 AM	0.3
10/14/2025	1:00:00 AM	0.3
10/14/2025	1:15:00 AM	0.3
10/14/2025	1:30:00 AM	0.3
10/14/2025	1:45:00 AM	0.3
10/14/2025	2:00:00 AM	0.3
10/14/2025	2:15:00 AM	0.3
10/14/2025	2:30:00 AM	0.3
10/14/2025	2:45:00 AM	0.3
10/14/2025	3:00:00 AM	0.3
10/14/2025	3:15:00 AM	0.3
10/14/2025	3:30:00 AM	0.3
10/14/2025	3:45:00 AM	0.3
10/14/2025	4:00:00 AM	0.3
10/14/2025	4:15:00 AM	0.3
10/14/2025	4:30:00 AM	0.3
10/14/2025	4:45:00 AM	0.3
10/14/2025	5:00:00 AM	0.3
10/14/2025	5:15:00 AM	0.3
10/14/2025	5:30:00 AM	0.3
10/14/2025	5:45:00 AM	0.3
10/14/2025	6:00:00 AM	0.3
10/14/2025	6:15:00 AM	0.3
10/14/2025	6:30:00 AM	0.3
10/14/2025	6:45:00 AM	0.3
10/14/2025	7:00:00 AM	0.3
10/14/2025	7:15:00 AM	0.3
10/14/2025	7:30:00 AM	0.3
10/14/2025	7:45:00 AM	0.3
10/14/2025	8:00:00 AM	0.3
10/14/2025	8:15:00 AM	0.3
10/14/2025	8:30:00 AM	0.3
10/14/2025	8:45:00 AM	0.3
10/14/2025	9:00:00 AM	0.3
10/14/2025	9:15:00 AM	0.3
10/14/2025	9:30:00 AM	0.3
10/14/2025	9:45:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
10/14/2025	10:00:00 AM	0.3
10/14/2025	10:15:00 AM	0.3
10/14/2025	10:30:00 AM	0.3
10/14/2025	10:45:00 AM	0.31
10/14/2025	11:00:00 AM	0.3
10/14/2025	11:15:00 AM	0.31
10/14/2025	11:30:00 AM	0.3
10/14/2025	11:45:00 AM	0.31
10/14/2025	12:00:00 PM	0.3
10/14/2025	12:15:00 PM	0.3
10/14/2025	12:30:00 PM	0.31
10/14/2025	12:45:00 PM	0.31
10/14/2025	1:00:00 PM	0.31
10/14/2025	1:15:00 PM	0.31
10/14/2025	1:30:00 PM	0.31
10/14/2025	1:45:00 PM	0.31
10/14/2025	2:00:00 PM	0.31
10/14/2025	2:15:00 PM	0.31
10/14/2025	2:30:00 PM	0.31
10/14/2025	2:45:00 PM	0.31
10/14/2025	3:00:00 PM	0.31
10/14/2025	3:15:00 PM	0.31
10/14/2025	3:30:00 PM	0.31
10/14/2025	3:45:00 PM	0.31
10/14/2025	4:00:00 PM	0.31
10/14/2025	4:15:00 PM	0.31
10/14/2025	4:30:00 PM	0.31
10/14/2025	4:45:00 PM	0.31
10/14/2025	5:00:00 PM	0.31
10/14/2025	5:15:00 PM	0.31
10/14/2025	5:30:00 PM	0.31
10/14/2025	5:45:00 PM	0.31
10/14/2025	6:00:00 PM	0.31
10/14/2025	6:15:00 PM	0.31
10/14/2025	6:30:00 PM	0.31
10/14/2025	6:45:00 PM	0.31
10/14/2025	7:00:00 PM	0.31
10/14/2025	7:15:00 PM	0.31
10/14/2025	7:30:00 PM	0.31
10/14/2025	7:45:00 PM	0.31
10/14/2025	8:00:00 PM	0.31
10/14/2025	8:15:00 PM	0.31
10/14/2025	8:30:00 PM	0.31
10/14/2025	8:45:00 PM	0.31
10/14/2025	9:00:00 PM	0.31
10/14/2025	9:15:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/14/2025	9:30:00 PM	0.31
10/14/2025	9:45:00 PM	0.31
10/14/2025	10:00:00 PM	0.31
10/14/2025	10:15:00 PM	0.31
10/14/2025	10:30:00 PM	0.31
10/14/2025	10:45:00 PM	0.31
10/14/2025	11:00:00 PM	0.31
10/14/2025	11:15:00 PM	0.31
10/14/2025	11:30:00 PM	0.31
10/14/2025	11:45:00 PM	0.31
10/15/2025	12:00:00 AM	0.31
10/15/2025	12:15:00 AM	0.31
10/15/2025	12:30:00 AM	0.31
10/15/2025	12:45:00 AM	0.31
10/15/2025	1:00:00 AM	0.31
10/15/2025	1:15:00 AM	0.31
10/15/2025	1:30:00 AM	0.31
10/15/2025	1:45:00 AM	0.31
10/15/2025	2:00:00 AM	0.31
10/15/2025	2:15:00 AM	0.31
10/15/2025	2:30:00 AM	0.31
10/15/2025	2:45:00 AM	0.31
10/15/2025	3:00:00 AM	0.31
10/15/2025	3:15:00 AM	0.31
10/15/2025	3:30:00 AM	0.31
10/15/2025	3:45:00 AM	0.31
10/15/2025	4:00:00 AM	0.31
10/15/2025	4:15:00 AM	0.31
10/15/2025	4:30:00 AM	0.31
10/15/2025	4:45:00 AM	0.31
10/15/2025	5:00:00 AM	0.31
10/15/2025	5:15:00 AM	0.31
10/15/2025	5:30:00 AM	0.31
10/15/2025	5:45:00 AM	0.31
10/15/2025	6:00:00 AM	0.31
10/15/2025	6:15:00 AM	0.31
10/15/2025	6:30:00 AM	0.31
10/15/2025	6:45:00 AM	0.31
10/15/2025	7:00:00 AM	0.31
10/15/2025	7:15:00 AM	0.31
10/15/2025	7:30:00 AM	0.31
10/15/2025	7:45:00 AM	0.31
10/15/2025	8:00:00 AM	0.31
10/15/2025	8:15:00 AM	0.31
10/15/2025	8:30:00 AM	0.31
10/15/2025	8:45:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/15/2025	9:00:00 AM	0.31
10/15/2025	9:15:00 AM	0.31
10/15/2025	9:30:00 AM	0.31
10/15/2025	9:45:00 AM	0.31
10/15/2025	10:00:00 AM	0.31
10/15/2025	10:15:00 AM	0.31
10/15/2025	10:30:00 AM	0.31
10/15/2025	10:45:00 AM	0.31
10/15/2025	11:00:00 AM	0.31
10/15/2025	11:15:00 AM	0.31
10/15/2025	11:30:00 AM	0.31
10/15/2025	11:45:00 AM	0.31
10/15/2025	12:00:00 PM	0.31
10/15/2025	12:15:00 PM	0.31
10/15/2025	12:30:00 PM	0.31
10/15/2025	12:45:00 PM	0.31
10/15/2025	1:00:00 PM	0.31
10/15/2025	1:15:00 PM	0.31
10/15/2025	1:30:00 PM	0.31
10/15/2025	1:45:00 PM	0.31
10/15/2025	2:00:00 PM	0.31
10/15/2025	2:15:00 PM	0.31
10/15/2025	2:30:00 PM	0.31
10/15/2025	2:45:00 PM	0.31
10/15/2025	3:00:00 PM	0.31
10/15/2025	3:15:00 PM	0.31
10/15/2025	3:30:00 PM	0.31
10/15/2025	3:45:00 PM	0.31
10/15/2025	4:00:00 PM	0.31
10/15/2025	4:15:00 PM	0.31
10/15/2025	4:30:00 PM	0.31
10/15/2025	4:45:00 PM	0.31
10/15/2025	5:00:00 PM	0.31
10/15/2025	5:15:00 PM	0.31
10/15/2025	5:30:00 PM	0.31
10/15/2025	5:45:00 PM	0.31
10/15/2025	6:00:00 PM	0.31
10/15/2025	6:15:00 PM	0.31
10/15/2025	6:30:00 PM	0.31
10/15/2025	6:45:00 PM	0.31
10/15/2025	7:00:00 PM	0.31
10/15/2025	7:15:00 PM	0.31
10/15/2025	7:30:00 PM	0.31
10/15/2025	7:45:00 PM	0.31
10/15/2025	8:00:00 PM	0.31
10/15/2025	8:15:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/15/2025	8:30:00 PM	0.31
10/15/2025	8:45:00 PM	0.31
10/15/2025	9:00:00 PM	0.31
10/15/2025	9:15:00 PM	0.31
10/15/2025	9:30:00 PM	0.31
10/15/2025	9:45:00 PM	0.31
10/15/2025	10:00:00 PM	0.31
10/15/2025	10:15:00 PM	0.31
10/15/2025	10:30:00 PM	0.31
10/15/2025	10:45:00 PM	0.31
10/15/2025	11:00:00 PM	0.31
10/15/2025	11:15:00 PM	0.31
10/15/2025	11:30:00 PM	0.31
10/15/2025	11:45:00 PM	0.31
10/16/2025	12:00:00 AM	0.31
10/16/2025	12:15:00 AM	0.31
10/16/2025	12:30:00 AM	0.31
10/16/2025	12:45:00 AM	0.31
10/16/2025	1:00:00 AM	0.31
10/16/2025	1:15:00 AM	0.31
10/16/2025	1:30:00 AM	0.31
10/16/2025	1:45:00 AM	0.31
10/16/2025	2:00:00 AM	0.31
10/16/2025	2:15:00 AM	0.31
10/16/2025	2:30:00 AM	0.31
10/16/2025	2:45:00 AM	0.31
10/16/2025	3:00:00 AM	0.31
10/16/2025	3:15:00 AM	0.31
10/16/2025	3:30:00 AM	0.31
10/16/2025	3:45:00 AM	0.31
10/16/2025	4:00:00 AM	0.31
10/16/2025	4:15:00 AM	0.31
10/16/2025	4:30:00 AM	0.31
10/16/2025	4:45:00 AM	0.31
10/16/2025	5:00:00 AM	0.31
10/16/2025	5:15:00 AM	0.31
10/16/2025	5:30:00 AM	0.31
10/16/2025	5:45:00 AM	0.31
10/16/2025	6:00:00 AM	0.31
10/16/2025	6:15:00 AM	0.31
10/16/2025	6:30:00 AM	0.31
10/16/2025	6:45:00 AM	0.31
10/16/2025	7:00:00 AM	0.31
10/16/2025	7:15:00 AM	0.31
10/16/2025	7:30:00 AM	0.31
10/16/2025	7:45:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/16/2025	8:00:00 AM	0.31
10/16/2025	8:15:00 AM	0.31
10/16/2025	8:30:00 AM	0.31
10/16/2025	8:45:00 AM	0.31
10/16/2025	9:00:00 AM	0.31
10/16/2025	9:15:00 AM	0.31
10/16/2025	9:30:00 AM	0.31
10/16/2025	9:45:00 AM	0.31
10/16/2025	10:00:00 AM	0.31
10/16/2025	10:15:00 AM	0.31
10/16/2025	10:30:00 AM	0.31
10/16/2025	10:45:00 AM	0.31
10/16/2025	11:00:00 AM	0.31
10/16/2025	11:15:00 AM	0.31
10/16/2025	11:30:00 AM	0.31
10/16/2025	11:45:00 AM	0.31
10/16/2025	12:00:00 PM	0.31
10/16/2025	12:15:00 PM	0.31
10/16/2025	12:30:00 PM	0.31
10/16/2025	12:45:00 PM	0.31
10/16/2025	1:00:00 PM	0.31
10/16/2025	1:15:00 PM	0.31
10/16/2025	1:30:00 PM	0.31
10/16/2025	1:45:00 PM	0.31
10/16/2025	2:00:00 PM	0.31
10/16/2025	2:15:00 PM	0.31
10/16/2025	2:30:00 PM	0.31
10/16/2025	2:45:00 PM	0.31
10/16/2025	3:00:00 PM	0.31
10/16/2025	3:15:00 PM	0.31
10/16/2025	3:30:00 PM	0.31
10/16/2025	3:45:00 PM	0.31
10/16/2025	4:00:00 PM	0.31
10/16/2025	4:15:00 PM	0.31
10/16/2025	4:30:00 PM	0.31
10/16/2025	4:45:00 PM	0.31
10/16/2025	5:00:00 PM	0.31
10/16/2025	5:15:00 PM	0.31
10/16/2025	5:30:00 PM	0.31
10/16/2025	5:45:00 PM	0.31
10/16/2025	6:00:00 PM	0.31
10/16/2025	6:15:00 PM	0.31
10/16/2025	6:30:00 PM	0.31
10/16/2025	6:45:00 PM	0.31
10/16/2025	7:00:00 PM	0.31
10/16/2025	7:15:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/16/2025	7:30:00 PM	0.31
10/16/2025	7:45:00 PM	0.31
10/16/2025	8:00:00 PM	0.31
10/16/2025	8:15:00 PM	0.31
10/16/2025	8:30:00 PM	0.31
10/16/2025	8:45:00 PM	0.31
10/16/2025	9:00:00 PM	0.31
10/16/2025	9:15:00 PM	0.31
10/16/2025	9:30:00 PM	0.31
10/16/2025	9:45:00 PM	0.31
10/16/2025	10:00:00 PM	0.31
10/16/2025	10:15:00 PM	0.31
10/16/2025	10:30:00 PM	0.31
10/16/2025	10:45:00 PM	0.31
10/16/2025	11:00:00 PM	0.31
10/16/2025	11:15:00 PM	0.31
10/16/2025	11:30:00 PM	0.31
10/16/2025	11:45:00 PM	0.31
10/17/2025	12:00:00 AM	0.31
10/17/2025	12:15:00 AM	0.31
10/17/2025	12:30:00 AM	0.31
10/17/2025	12:45:00 AM	0.31
10/17/2025	1:00:00 AM	0.31
10/17/2025	1:15:00 AM	0.31
10/17/2025	1:30:00 AM	0.31
10/17/2025	1:45:00 AM	0.31
10/17/2025	2:00:00 AM	0.31
10/17/2025	2:15:00 AM	0.31
10/17/2025	2:30:00 AM	0.31
10/17/2025	2:45:00 AM	0.31
10/17/2025	3:00:00 AM	0.31
10/17/2025	3:15:00 AM	0.31
10/17/2025	3:30:00 AM	0.31
10/17/2025	3:45:00 AM	0.31
10/17/2025	4:00:00 AM	0.31
10/17/2025	4:15:00 AM	0.31
10/17/2025	4:30:00 AM	0.31
10/17/2025	4:45:00 AM	0.31
10/17/2025	5:00:00 AM	0.31
10/17/2025	5:15:00 AM	0.31
10/17/2025	5:30:00 AM	0.31
10/17/2025	5:45:00 AM	0.31
10/17/2025	6:00:00 AM	0.31
10/17/2025	6:15:00 AM	0.31
10/17/2025	6:30:00 AM	0.31
10/17/2025	6:45:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/17/2025	7:00:00 AM	0.31
10/17/2025	7:15:00 AM	0.31
10/17/2025	7:30:00 AM	0.31
10/17/2025	7:45:00 AM	0.31
10/17/2025	8:00:00 AM	0.31
10/17/2025	8:15:00 AM	0.31
10/17/2025	8:30:00 AM	0.31
10/17/2025	8:45:00 AM	0.31
10/17/2025	9:00:00 AM	0.31
10/17/2025	9:15:00 AM	0.31
10/17/2025	9:30:00 AM	0.31
10/17/2025	9:45:00 AM	0.31
10/17/2025	10:00:00 AM	0.31
10/17/2025	10:15:00 AM	0.31
10/17/2025	10:30:00 AM	0.31
10/17/2025	10:45:00 AM	0.31
10/17/2025	11:00:00 AM	0.31
10/17/2025	11:15:00 AM	0.31
10/17/2025	11:30:00 AM	0.31
10/17/2025	11:45:00 AM	0.31
10/17/2025	12:00:00 PM	0.31
10/17/2025	12:15:00 PM	0.31
10/17/2025	12:30:00 PM	0.31
10/17/2025	12:45:00 PM	0.31
10/17/2025	1:00:00 PM	0.31
10/17/2025	1:15:00 PM	0.31
10/17/2025	1:30:00 PM	0.31
10/17/2025	1:45:00 PM	0.31
10/17/2025	2:00:00 PM	0.31
10/17/2025	2:15:00 PM	0.31
10/17/2025	2:30:00 PM	0.31
10/17/2025	2:45:00 PM	0.31
10/17/2025	3:00:00 PM	0.31
10/17/2025	3:15:00 PM	0.31
10/17/2025	3:30:00 PM	0.31
10/17/2025	3:45:00 PM	0.31
10/17/2025	4:00:00 PM	0.31
10/17/2025	4:15:00 PM	0.31
10/17/2025	4:30:00 PM	0.31
10/17/2025	4:45:00 PM	0.31
10/17/2025	5:00:00 PM	0.31
10/17/2025	5:15:00 PM	0.31
10/17/2025	5:30:00 PM	0.31
10/17/2025	5:45:00 PM	0.31
10/17/2025	6:00:00 PM	0.31
10/17/2025	6:15:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/17/2025	6:30:00 PM	0.31
10/17/2025	6:45:00 PM	0.31
10/17/2025	7:00:00 PM	0.31
10/17/2025	7:15:00 PM	0.31
10/17/2025	7:30:00 PM	0.31
10/17/2025	7:45:00 PM	0.31
10/17/2025	8:00:00 PM	0.31
10/17/2025	8:15:00 PM	0.31
10/17/2025	8:30:00 PM	0.31
10/17/2025	8:45:00 PM	0.31
10/17/2025	9:00:00 PM	0.31
10/17/2025	9:15:00 PM	0.31
10/17/2025	9:30:00 PM	0.31
10/17/2025	9:45:00 PM	0.31
10/17/2025	10:00:00 PM	0.31
10/17/2025	10:15:00 PM	0.31
10/17/2025	10:30:00 PM	0.31
10/17/2025	10:45:00 PM	0.31
10/17/2025	11:00:00 PM	0.31
10/17/2025	11:15:00 PM	0.31
10/17/2025	11:30:00 PM	0.31
10/17/2025	11:45:00 PM	0.31
10/18/2025	12:00:00 AM	0.31
10/18/2025	12:15:00 AM	0.31
10/18/2025	12:30:00 AM	0.31
10/18/2025	12:45:00 AM	0.31
10/18/2025	1:00:00 AM	0.31
10/18/2025	1:15:00 AM	0.31
10/18/2025	1:30:00 AM	0.31
10/18/2025	1:45:00 AM	0.31
10/18/2025	2:00:00 AM	0.31
10/18/2025	2:15:00 AM	0.31
10/18/2025	2:30:00 AM	0.31
10/18/2025	2:45:00 AM	0.31
10/18/2025	3:00:00 AM	0.31
10/18/2025	3:15:00 AM	0.31
10/18/2025	3:30:00 AM	0.31
10/18/2025	3:45:00 AM	0.31
10/18/2025	4:00:00 AM	0.31
10/18/2025	4:15:00 AM	0.31
10/18/2025	4:30:00 AM	0.31
10/18/2025	4:45:00 AM	0.31
10/18/2025	5:00:00 AM	0.31
10/18/2025	5:15:00 AM	0.31
10/18/2025	5:30:00 AM	0.31
10/18/2025	5:45:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/18/2025	6:00:00 AM	0.31
10/18/2025	6:15:00 AM	0.31
10/18/2025	6:30:00 AM	0.31
10/18/2025	6:45:00 AM	0.31
10/18/2025	7:00:00 AM	0.31
10/18/2025	7:15:00 AM	0.31
10/18/2025	7:30:00 AM	0.31
10/18/2025	7:45:00 AM	0.31
10/18/2025	8:00:00 AM	0.31
10/18/2025	8:15:00 AM	0.31
10/18/2025	8:30:00 AM	0.31
10/18/2025	8:45:00 AM	0.31
10/18/2025	9:00:00 AM	0.31
10/18/2025	9:15:00 AM	0.31
10/18/2025	9:30:00 AM	0.31
10/18/2025	9:45:00 AM	0.31
10/18/2025	10:00:00 AM	0.31
10/18/2025	10:15:00 AM	0.31
10/18/2025	10:30:00 AM	0.31
10/18/2025	10:45:00 AM	0.31
10/18/2025	11:00:00 AM	0.31
10/18/2025	11:15:00 AM	0.31
10/18/2025	11:30:00 AM	0.31
10/18/2025	11:45:00 AM	0.31
10/18/2025	12:00:00 PM	0.31
10/18/2025	12:15:00 PM	0.31
10/18/2025	12:30:00 PM	0.31
10/18/2025	12:45:00 PM	0.31
10/18/2025	1:00:00 PM	0.31
10/18/2025	1:15:00 PM	0.31
10/18/2025	1:30:00 PM	0.31
10/18/2025	1:45:00 PM	0.31
10/18/2025	2:00:00 PM	0.31
10/18/2025	2:15:00 PM	0.31
10/18/2025	2:30:00 PM	0.31
10/18/2025	2:45:00 PM	0.31
10/18/2025	3:00:00 PM	0.31
10/18/2025	3:15:00 PM	0.31
10/18/2025	3:30:00 PM	0.31
10/18/2025	3:45:00 PM	0.31
10/18/2025	4:00:00 PM	0.31
10/18/2025	4:15:00 PM	0.31
10/18/2025	4:30:00 PM	0.31
10/18/2025	4:45:00 PM	0.31
10/18/2025	5:00:00 PM	0.31
10/18/2025	5:15:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/18/2025	5:30:00 PM	0.31
10/18/2025	5:45:00 PM	0.31
10/18/2025	6:00:00 PM	0.31
10/18/2025	6:15:00 PM	0.31
10/18/2025	6:30:00 PM	0.31
10/18/2025	6:45:00 PM	0.31
10/18/2025	7:00:00 PM	0.31
10/18/2025	7:15:00 PM	0.31
10/18/2025	7:30:00 PM	0.31
10/18/2025	7:45:00 PM	0.31
10/18/2025	8:00:00 PM	0.31
10/18/2025	8:15:00 PM	0.31
10/18/2025	8:30:00 PM	0.31
10/18/2025	8:45:00 PM	0.31
10/18/2025	9:00:00 PM	0.31
10/18/2025	9:15:00 PM	0.31
10/18/2025	9:30:00 PM	0.31
10/18/2025	9:45:00 PM	0.31
10/18/2025	10:00:00 PM	0.31
10/18/2025	10:15:00 PM	0.31
10/18/2025	10:30:00 PM	0.31
10/18/2025	10:45:00 PM	0.31
10/18/2025	11:00:00 PM	0.31
10/18/2025	11:15:00 PM	0.31
10/18/2025	11:30:00 PM	0.31
10/18/2025	11:45:00 PM	0.31
10/19/2025	12:00:00 AM	0.31
10/19/2025	12:15:00 AM	0.31
10/19/2025	12:30:00 AM	0.31
10/19/2025	12:45:00 AM	0.31
10/19/2025	1:00:00 AM	0.3
10/19/2025	1:15:00 AM	0.31
10/19/2025	1:30:00 AM	0.31
10/19/2025	1:45:00 AM	0.31
10/19/2025	2:00:00 AM	0.31
10/19/2025	2:15:00 AM	0.31
10/19/2025	2:30:00 AM	0.31
10/19/2025	2:45:00 AM	0.31
10/19/2025	3:00:00 AM	0.3
10/19/2025	3:15:00 AM	0.31
10/19/2025	3:30:00 AM	0.31
10/19/2025	3:45:00 AM	0.31
10/19/2025	4:00:00 AM	0.31
10/19/2025	4:15:00 AM	0.31
10/19/2025	4:30:00 AM	0.31
10/19/2025	4:45:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/19/2025	5:00:00 AM	0.3
10/19/2025	5:15:00 AM	0.31
10/19/2025	5:30:00 AM	0.31
10/19/2025	5:45:00 AM	0.31
10/19/2025	6:00:00 AM	0.3
10/19/2025	6:15:00 AM	0.31
10/19/2025	6:30:00 AM	0.31
10/19/2025	6:45:00 AM	0.31
10/19/2025	7:00:00 AM	0.31
10/19/2025	7:15:00 AM	0.31
10/19/2025	7:30:00 AM	0.3
10/19/2025	7:45:00 AM	0.3
10/19/2025	8:00:00 AM	0.31
10/19/2025	8:15:00 AM	0.31
10/19/2025	8:30:00 AM	0.31
10/19/2025	8:45:00 AM	0.3
10/19/2025	9:00:00 AM	0.31
10/19/2025	9:15:00 AM	0.31
10/19/2025	9:30:00 AM	0.3
10/19/2025	9:45:00 AM	0.31
10/19/2025	10:00:00 AM	0.31
10/19/2025	10:15:00 AM	0.31
10/19/2025	10:30:00 AM	0.3
10/19/2025	10:45:00 AM	0.31
10/19/2025	11:00:00 AM	0.31
10/19/2025	11:15:00 AM	0.31
10/19/2025	11:30:00 AM	0.3
10/19/2025	11:45:00 AM	0.31
10/19/2025	12:00:00 PM	0.3
10/19/2025	12:15:00 PM	0.3
10/19/2025	12:30:00 PM	0.31
10/19/2025	12:45:00 PM	0.31
10/19/2025	1:00:00 PM	0.3
10/19/2025	1:15:00 PM	0.3
10/19/2025	1:30:00 PM	0.3
10/19/2025	1:45:00 PM	0.31
10/19/2025	2:00:00 PM	0.31
10/19/2025	2:15:00 PM	0.3
10/19/2025	2:30:00 PM	0.3
10/19/2025	2:45:00 PM	0.31
10/19/2025	3:00:00 PM	0.3
10/19/2025	3:15:00 PM	0.31
10/19/2025	3:30:00 PM	0.31
10/19/2025	3:45:00 PM	0.31
10/19/2025	4:00:00 PM	0.31
10/19/2025	4:15:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
10/19/2025	4:30:00 PM	0.31
10/19/2025	4:45:00 PM	0.31
10/19/2025	5:00:00 PM	0.31
10/19/2025	5:15:00 PM	0.31
10/19/2025	5:30:00 PM	0.31
10/19/2025	5:45:00 PM	0.31
10/19/2025	6:00:00 PM	0.31
10/19/2025	6:15:00 PM	0.31
10/19/2025	6:30:00 PM	0.31
10/19/2025	6:45:00 PM	0.31
10/19/2025	7:00:00 PM	0.31
10/19/2025	7:15:00 PM	0.31
10/19/2025	7:30:00 PM	0.31
10/19/2025	7:45:00 PM	0.31
10/19/2025	8:00:00 PM	0.31
10/19/2025	8:15:00 PM	0.31
10/19/2025	8:30:00 PM	0.31
10/19/2025	8:45:00 PM	0.31
10/19/2025	9:00:00 PM	0.31
10/19/2025	9:15:00 PM	0.31
10/19/2025	9:30:00 PM	0.31
10/19/2025	9:45:00 PM	0.31
10/19/2025	10:00:00 PM	0.31
10/19/2025	10:15:00 PM	0.31
10/19/2025	10:30:00 PM	0.31
10/19/2025	10:45:00 PM	0.31
10/19/2025	11:00:00 PM	0.31
10/19/2025	11:15:00 PM	0.31
10/19/2025	11:30:00 PM	0.31
10/19/2025	11:45:00 PM	0.31
10/20/2025	12:00:00 AM	0.31
10/20/2025	12:15:00 AM	0.31
10/20/2025	12:30:00 AM	0.31
10/20/2025	12:45:00 AM	0.31
10/20/2025	1:00:00 AM	0.31
10/20/2025	1:15:00 AM	0.31
10/20/2025	1:30:00 AM	0.31
10/20/2025	1:45:00 AM	0.31
10/20/2025	2:00:00 AM	0.31
10/20/2025	2:15:00 AM	0.31
10/20/2025	2:30:00 AM	0.31
10/20/2025	2:45:00 AM	0.31
10/20/2025	3:00:00 AM	0.31
10/20/2025	3:15:00 AM	0.31
10/20/2025	3:30:00 AM	0.31
10/20/2025	3:45:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/20/2025	4:00:00 AM	0.31
10/20/2025	4:15:00 AM	0.31
10/20/2025	4:30:00 AM	0.31
10/20/2025	4:45:00 AM	0.31
10/20/2025	5:00:00 AM	0.31
10/20/2025	5:15:00 AM	0.31
10/20/2025	5:30:00 AM	0.31
10/20/2025	5:45:00 AM	0.31
10/20/2025	6:00:00 AM	0.31
10/20/2025	6:15:00 AM	0.31
10/20/2025	6:30:00 AM	0.31
10/20/2025	6:45:00 AM	0.31
10/20/2025	7:00:00 AM	0.31
10/20/2025	7:15:00 AM	0.31
10/20/2025	7:30:00 AM	0.31
10/20/2025	7:45:00 AM	0.31
10/20/2025	8:00:00 AM	0.31
10/20/2025	8:15:00 AM	0.31
10/20/2025	8:30:00 AM	0.31
10/20/2025	8:45:00 AM	0.31
10/20/2025	9:00:00 AM	0.31
10/20/2025	9:15:00 AM	0.31
10/20/2025	9:30:00 AM	0.31
10/20/2025	9:45:00 AM	0.31
10/20/2025	10:00:00 AM	0.31
10/20/2025	10:15:00 AM	0.31
10/20/2025	10:30:00 AM	0.31
10/20/2025	10:45:00 AM	0.31
10/20/2025	11:00:00 AM	0.31
10/20/2025	11:15:00 AM	0.31
10/20/2025	11:30:00 AM	0.31
10/20/2025	11:45:00 AM	0.31
10/20/2025	12:00:00 PM	0.31
10/20/2025	12:15:00 PM	0.31
10/20/2025	12:30:00 PM	0.31
10/20/2025	12:45:00 PM	0.31
10/20/2025	1:00:00 PM	0.31
10/20/2025	1:15:00 PM	0.31
10/20/2025	1:30:00 PM	0.31
10/20/2025	1:45:00 PM	0.31
10/20/2025	2:00:00 PM	0.31
10/20/2025	2:15:00 PM	0.31
10/20/2025	2:30:00 PM	0.31
10/20/2025	2:45:00 PM	0.31
10/20/2025	3:00:00 PM	0.31
10/20/2025	3:15:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/20/2025	3:30:00 PM	0.31
10/20/2025	3:45:00 PM	0.31
10/20/2025	4:00:00 PM	0.31
10/20/2025	4:15:00 PM	0.31
10/20/2025	4:30:00 PM	0.31
10/20/2025	4:45:00 PM	0.31
10/20/2025	5:00:00 PM	0.31
10/20/2025	5:15:00 PM	0.31
10/20/2025	5:30:00 PM	0.31
10/20/2025	5:45:00 PM	0.31
10/20/2025	6:00:00 PM	0.31
10/20/2025	6:15:00 PM	0.31
10/20/2025	6:30:00 PM	0.31
10/20/2025	6:45:00 PM	0.31
10/20/2025	7:00:00 PM	0.31
10/20/2025	7:15:00 PM	0.31
10/20/2025	7:30:00 PM	0.31
10/20/2025	7:45:00 PM	0.31
10/20/2025	8:00:00 PM	0.31
10/20/2025	8:15:00 PM	0.31
10/20/2025	8:30:00 PM	0.31
10/20/2025	8:45:00 PM	0.31
10/20/2025	9:00:00 PM	0.31
10/20/2025	9:15:00 PM	0.31
10/20/2025	9:30:00 PM	0.31
10/20/2025	9:45:00 PM	0.31
10/20/2025	10:00:00 PM	0.31
10/20/2025	10:15:00 PM	0.31
10/20/2025	10:30:00 PM	0.31
10/20/2025	10:45:00 PM	0.31
10/20/2025	11:00:00 PM	0.31
10/20/2025	11:15:00 PM	0.31
10/20/2025	11:30:00 PM	0.31
10/20/2025	11:45:00 PM	0.31
10/21/2025	12:00:00 AM	0.31
10/21/2025	12:15:00 AM	0.31
10/21/2025	12:30:00 AM	0.31
10/21/2025	12:45:00 AM	0.31
10/21/2025	1:00:00 AM	0.31
10/21/2025	1:15:00 AM	0.31
10/21/2025	1:30:00 AM	0.31
10/21/2025	1:45:00 AM	0.31
10/21/2025	2:00:00 AM	0.31
10/21/2025	2:15:00 AM	0.31
10/21/2025	2:30:00 AM	0.31
10/21/2025	2:45:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/21/2025	3:00:00 AM	0.31
10/21/2025	3:15:00 AM	0.31
10/21/2025	3:30:00 AM	0.31
10/21/2025	3:45:00 AM	0.31
10/21/2025	4:00:00 AM	0.31
10/21/2025	4:15:00 AM	0.31
10/21/2025	4:30:00 AM	0.31
10/21/2025	4:45:00 AM	0.31
10/21/2025	5:00:00 AM	0.31
10/21/2025	5:15:00 AM	0.31
10/21/2025	5:30:00 AM	0.31
10/21/2025	5:45:00 AM	0.31
10/21/2025	6:00:00 AM	0.31
10/21/2025	6:15:00 AM	0.31
10/21/2025	6:30:00 AM	0.31
10/21/2025	6:45:00 AM	0.31
10/21/2025	7:00:00 AM	0.31
10/21/2025	7:15:00 AM	0.31
10/21/2025	7:30:00 AM	0.31
10/21/2025	7:45:00 AM	0.31
10/21/2025	8:00:00 AM	0.31
10/21/2025	8:15:00 AM	0.31
10/21/2025	8:30:00 AM	0.31
10/21/2025	8:45:00 AM	0.31
10/21/2025	9:00:00 AM	0.31
10/21/2025	9:15:00 AM	0.31
10/21/2025	9:30:00 AM	0.31
10/21/2025	9:45:00 AM	0.31
10/21/2025	10:00:00 AM	0.31
10/21/2025	10:15:00 AM	0.31
10/21/2025	10:30:00 AM	0.31
10/21/2025	10:45:00 AM	0.31
10/21/2025	11:00:00 AM	0.31
10/21/2025	11:15:00 AM	0.31
10/21/2025	11:30:00 AM	0.31
10/21/2025	11:45:00 AM	0.31
10/21/2025	12:00:00 PM	0.31
10/21/2025	12:15:00 PM	0.31
10/21/2025	12:30:00 PM	0.31
10/21/2025	12:45:00 PM	0.31
10/21/2025	1:00:00 PM	0.31
10/21/2025	1:15:00 PM	0.31
10/21/2025	1:30:00 PM	0.31
10/21/2025	1:45:00 PM	0.31
10/21/2025	2:00:00 PM	0.31
10/21/2025	2:15:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/21/2025	2:30:00 PM	0.31
10/21/2025	2:45:00 PM	0.31
10/21/2025	3:00:00 PM	0.31
10/21/2025	3:15:00 PM	0.31
10/21/2025	3:30:00 PM	0.31
10/21/2025	3:45:00 PM	0.31
10/21/2025	4:00:00 PM	0.31
10/21/2025	4:15:00 PM	0.31
10/21/2025	4:30:00 PM	0.31
10/21/2025	4:45:00 PM	0.31
10/21/2025	5:00:00 PM	0.31
10/21/2025	5:15:00 PM	0.31
10/21/2025	5:30:00 PM	0.31
10/21/2025	5:45:00 PM	0.31
10/21/2025	6:00:00 PM	0.31
10/21/2025	6:15:00 PM	0.31
10/21/2025	6:30:00 PM	0.31
10/21/2025	6:45:00 PM	0.31
10/21/2025	7:00:00 PM	0.31
10/21/2025	7:15:00 PM	0.31
10/21/2025	7:30:00 PM	0.31
10/21/2025	7:45:00 PM	0.31
10/21/2025	8:00:00 PM	0.31
10/21/2025	8:15:00 PM	0.31
10/21/2025	8:30:00 PM	0.31
10/21/2025	8:45:00 PM	0.31
10/21/2025	9:00:00 PM	0.31
10/21/2025	9:15:00 PM	0.31
10/21/2025	9:30:00 PM	0.31
10/21/2025	9:45:00 PM	0.31
10/21/2025	10:00:00 PM	0.31
10/21/2025	10:15:00 PM	0.31
10/21/2025	10:30:00 PM	0.31
10/21/2025	10:45:00 PM	0.31
10/21/2025	11:00:00 PM	0.31
10/21/2025	11:15:00 PM	0.31
10/21/2025	11:30:00 PM	0.31
10/21/2025	11:45:00 PM	0.31
10/22/2025	12:00:00 AM	0.31
10/22/2025	12:15:00 AM	0.31
10/22/2025	12:30:00 AM	0.31
10/22/2025	12:45:00 AM	0.31
10/22/2025	1:00:00 AM	0.31
10/22/2025	1:15:00 AM	0.31
10/22/2025	1:30:00 AM	0.31
10/22/2025	1:45:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/22/2025	2:00:00 AM	0.31
10/22/2025	2:15:00 AM	0.31
10/22/2025	2:30:00 AM	0.31
10/22/2025	2:45:00 AM	0.31
10/22/2025	3:00:00 AM	0.31
10/22/2025	3:15:00 AM	0.31
10/22/2025	3:30:00 AM	0.31
10/22/2025	3:45:00 AM	0.31
10/22/2025	4:00:00 AM	0.31
10/22/2025	4:15:00 AM	0.31
10/22/2025	4:30:00 AM	0.31
10/22/2025	4:45:00 AM	0.31
10/22/2025	5:00:00 AM	0.31
10/22/2025	5:15:00 AM	0.31
10/22/2025	5:30:00 AM	0.31
10/22/2025	5:45:00 AM	0.31
10/22/2025	6:00:00 AM	0.31
10/22/2025	6:15:00 AM	0.31
10/22/2025	6:30:00 AM	0.31
10/22/2025	6:45:00 AM	0.31
10/22/2025	7:00:00 AM	0.31
10/22/2025	7:15:00 AM	0.31
10/22/2025	7:30:00 AM	0.31
10/22/2025	7:45:00 AM	0.31
10/22/2025	8:00:00 AM	0.31
10/22/2025	8:15:00 AM	0.31
10/22/2025	8:30:00 AM	0.31
10/22/2025	8:45:00 AM	0.31
10/22/2025	9:00:00 AM	0.31
10/22/2025	9:15:00 AM	0.31
10/22/2025	9:30:00 AM	0.31
10/22/2025	9:45:00 AM	0.31
10/22/2025	10:00:00 AM	0.31
10/22/2025	10:15:00 AM	0.31
10/22/2025	10:30:00 AM	0.31
10/22/2025	10:45:00 AM	0.31
10/22/2025	11:00:00 AM	0.31
10/22/2025	11:15:00 AM	0.31
10/22/2025	11:30:00 AM	0.31
10/22/2025	11:45:00 AM	0.31
10/22/2025	12:00:00 PM	0.31
10/22/2025	12:15:00 PM	0.31
10/22/2025	12:30:00 PM	0.31
10/22/2025	12:45:00 PM	0.31
10/22/2025	1:00:00 PM	0.31
10/22/2025	1:15:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/22/2025	1:30:00 PM	0.31
10/22/2025	1:45:00 PM	0.31
10/22/2025	2:00:00 PM	0.31
10/22/2025	2:15:00 PM	0.31
10/22/2025	2:30:00 PM	0.31
10/22/2025	2:45:00 PM	0.31
10/22/2025	3:00:00 PM	0.31
10/22/2025	3:15:00 PM	0.31
10/22/2025	3:30:00 PM	0.31
10/22/2025	3:45:00 PM	0.3
10/22/2025	4:00:00 PM	0.3
10/22/2025	4:15:00 PM	0.3
10/22/2025	4:30:00 PM	0.3
10/22/2025	4:45:00 PM	0.3
10/22/2025	5:00:00 PM	0.3
10/22/2025	5:15:00 PM	0.3
10/22/2025	5:30:00 PM	0.29
10/22/2025	5:45:00 PM	0.29
10/22/2025	6:00:00 PM	0.29
10/22/2025	6:15:00 PM	0.29
10/22/2025	6:30:00 PM	0.29
10/22/2025	6:45:00 PM	0.29
10/22/2025	7:00:00 PM	0.29
10/22/2025	7:15:00 PM	0.29
10/22/2025	7:30:00 PM	0.29
10/22/2025	7:45:00 PM	0.29
10/22/2025	8:00:00 PM	0.29
10/22/2025	8:15:00 PM	0.29
10/22/2025	8:30:00 PM	0.29
10/22/2025	8:45:00 PM	0.29
10/22/2025	9:00:00 PM	0.29
10/22/2025	9:15:00 PM	0.29
10/22/2025	9:30:00 PM	0.29
10/22/2025	9:45:00 PM	0.29
10/22/2025	10:00:00 PM	0.29
10/22/2025	10:15:00 PM	0.29
10/22/2025	10:30:00 PM	0.28
10/22/2025	10:45:00 PM	0.28
10/22/2025	11:00:00 PM	0.28
10/22/2025	11:15:00 PM	0.28
10/22/2025	11:30:00 PM	0.28
10/22/2025	11:45:00 PM	0.28
10/23/2025	12:00:00 AM	0.28
10/23/2025	12:15:00 AM	0.28
10/23/2025	12:30:00 AM	0.28
10/23/2025	12:45:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
10/23/2025	1:00:00 AM	0.28
10/23/2025	1:15:00 AM	0.28
10/23/2025	1:30:00 AM	0.28
10/23/2025	1:45:00 AM	0.28
10/23/2025	2:00:00 AM	0.28
10/23/2025	2:15:00 AM	0.28
10/23/2025	2:30:00 AM	0.28
10/23/2025	2:45:00 AM	0.28
10/23/2025	3:00:00 AM	0.28
10/23/2025	3:15:00 AM	0.28
10/23/2025	3:30:00 AM	0.28
10/23/2025	3:45:00 AM	0.28
10/23/2025	4:00:00 AM	0.28
10/23/2025	4:15:00 AM	0.28
10/23/2025	4:30:00 AM	0.28
10/23/2025	4:45:00 AM	0.28
10/23/2025	5:00:00 AM	0.28
10/23/2025	5:15:00 AM	0.28
10/23/2025	5:30:00 AM	0.28
10/23/2025	5:45:00 AM	0.28
10/23/2025	6:00:00 AM	0.28
10/23/2025	6:15:00 AM	0.28
10/23/2025	6:30:00 AM	0.28
10/23/2025	6:45:00 AM	0.28
10/23/2025	7:00:00 AM	0.28
10/23/2025	7:15:00 AM	0.28
10/23/2025	7:30:00 AM	0.28
10/23/2025	7:45:00 AM	0.28
10/23/2025	8:00:00 AM	0.28
10/23/2025	8:15:00 AM	0.28
10/23/2025	8:30:00 AM	0.28
10/23/2025	8:45:00 AM	0.28
10/23/2025	9:00:00 AM	0.28
10/23/2025	9:15:00 AM	0.28
10/23/2025	9:30:00 AM	0.28
10/23/2025	9:45:00 AM	0.28
10/23/2025	10:00:00 AM	0.28
10/23/2025	10:15:00 AM	0.28
10/23/2025	10:30:00 AM	0.27
10/23/2025	10:45:00 AM	0.28
10/23/2025	11:00:00 AM	0.28
10/23/2025	11:15:00 AM	0.28
10/23/2025	11:30:00 AM	0.28
10/23/2025	11:45:00 AM	0.27
10/23/2025	12:00:00 PM	0.27
10/23/2025	12:15:00 PM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
10/23/2025	12:30:00 PM	0.27
10/23/2025	12:45:00 PM	0.27
10/23/2025	1:00:00 PM	0.27
10/23/2025	1:15:00 PM	0.27
10/23/2025	1:30:00 PM	0.27
10/23/2025	1:45:00 PM	0.27
10/23/2025	2:00:00 PM	0.27
10/23/2025	2:15:00 PM	0.27
10/23/2025	2:30:00 PM	0.27
10/23/2025	2:45:00 PM	0.27
10/23/2025	3:00:00 PM	0.27
10/23/2025	3:15:00 PM	0.27
10/23/2025	3:30:00 PM	0.27
10/23/2025	3:45:00 PM	0.27
10/23/2025	4:00:00 PM	0.27
10/23/2025	4:15:00 PM	0.27
10/23/2025	4:30:00 PM	0.27
10/23/2025	4:45:00 PM	0.27
10/23/2025	5:00:00 PM	0.27
10/23/2025	5:15:00 PM	0.27
10/23/2025	5:30:00 PM	0.27
10/23/2025	5:45:00 PM	0.27
10/23/2025	6:00:00 PM	0.27
10/23/2025	6:15:00 PM	0.27
10/23/2025	6:30:00 PM	0.27
10/23/2025	6:45:00 PM	0.27
10/23/2025	7:00:00 PM	0.27
10/23/2025	7:15:00 PM	0.27
10/23/2025	7:30:00 PM	0.27
10/23/2025	7:45:00 PM	0.27
10/23/2025	8:00:00 PM	0.27
10/23/2025	8:15:00 PM	0.27
10/23/2025	8:30:00 PM	0.27
10/23/2025	8:45:00 PM	0.27
10/23/2025	9:00:00 PM	0.27
10/23/2025	9:15:00 PM	0.27
10/23/2025	9:30:00 PM	0.27
10/23/2025	9:45:00 PM	0.27
10/23/2025	10:00:00 PM	0.27
10/23/2025	10:15:00 PM	0.27
10/23/2025	10:30:00 PM	0.27
10/23/2025	10:45:00 PM	0.27
10/23/2025	11:00:00 PM	0.27
10/23/2025	11:15:00 PM	0.27
10/23/2025	11:30:00 PM	0.27
10/23/2025	11:45:00 PM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
10/24/2025	12:00:00 AM	0.27
10/24/2025	12:15:00 AM	0.27
10/24/2025	12:30:00 AM	0.27
10/24/2025	12:45:00 AM	0.27
10/24/2025	1:00:00 AM	0.27
10/24/2025	1:15:00 AM	0.27
10/24/2025	1:30:00 AM	0.27
10/24/2025	1:45:00 AM	0.27
10/24/2025	2:00:00 AM	0.27
10/24/2025	2:15:00 AM	0.27
10/24/2025	2:30:00 AM	0.27
10/24/2025	2:45:00 AM	0.27
10/24/2025	3:00:00 AM	0.27
10/24/2025	3:15:00 AM	0.27
10/24/2025	3:30:00 AM	0.27
10/24/2025	3:45:00 AM	0.27
10/24/2025	4:00:00 AM	0.27
10/24/2025	4:15:00 AM	0.27
10/24/2025	4:30:00 AM	0.28
10/24/2025	4:45:00 AM	0.28
10/24/2025	5:00:00 AM	0.28
10/24/2025	5:15:00 AM	0.27
10/24/2025	5:30:00 AM	0.27
10/24/2025	5:45:00 AM	0.28
10/24/2025	6:00:00 AM	0.28
10/24/2025	6:15:00 AM	0.28
10/24/2025	6:30:00 AM	0.28
10/24/2025	6:45:00 AM	0.28
10/24/2025	7:00:00 AM	0.29
10/24/2025	7:15:00 AM	0.29
10/24/2025	7:30:00 AM	0.29
10/24/2025	7:45:00 AM	0.29
10/24/2025	8:00:00 AM	0.29
10/24/2025	8:15:00 AM	0.29
10/24/2025	8:30:00 AM	0.29
10/24/2025	8:45:00 AM	0.3
10/24/2025	9:00:00 AM	0.3
10/24/2025	9:15:00 AM	0.3
10/24/2025	9:30:00 AM	0.3
10/24/2025	9:45:00 AM	0.3
10/24/2025	10:00:00 AM	0.3
10/24/2025	10:15:00 AM	0.3
10/24/2025	10:30:00 AM	0.3
10/24/2025	10:45:00 AM	0.3
10/24/2025	11:00:00 AM	0.3
10/24/2025	11:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
10/24/2025	11:30:00 AM	0.31
10/24/2025	11:45:00 AM	0.31
10/24/2025	12:00:00 PM	0.31
10/24/2025	12:15:00 PM	0.31
10/24/2025	12:30:00 PM	0.31
10/24/2025	12:45:00 PM	0.31
10/24/2025	1:00:00 PM	0.31
10/24/2025	1:15:00 PM	0.31
10/24/2025	1:30:00 PM	0.31
10/24/2025	1:45:00 PM	0.31
10/24/2025	2:00:00 PM	0.31
10/24/2025	2:15:00 PM	0.31
10/24/2025	2:30:00 PM	0.31
10/24/2025	2:45:00 PM	0.31
10/24/2025	3:00:00 PM	0.31
10/24/2025	3:15:00 PM	0.31
10/24/2025	3:30:00 PM	0.31
10/24/2025	3:45:00 PM	0.31
10/24/2025	4:00:00 PM	0.31
10/24/2025	4:15:00 PM	0.31
10/24/2025	4:30:00 PM	0.31
10/24/2025	4:45:00 PM	0.31
10/24/2025	5:00:00 PM	0.31
10/24/2025	5:15:00 PM	0.32
10/24/2025	5:30:00 PM	0.31
10/24/2025	5:45:00 PM	0.31
10/24/2025	6:00:00 PM	0.31
10/24/2025	6:15:00 PM	0.32
10/24/2025	6:30:00 PM	0.32
10/24/2025	6:45:00 PM	0.32
10/24/2025	7:00:00 PM	0.32
10/24/2025	7:15:00 PM	0.32
10/24/2025	7:30:00 PM	0.32
10/24/2025	7:45:00 PM	0.32
10/24/2025	8:00:00 PM	0.32
10/24/2025	8:15:00 PM	0.32
10/24/2025	8:30:00 PM	0.32
10/24/2025	8:45:00 PM	0.32
10/24/2025	9:00:00 PM	0.32
10/24/2025	9:15:00 PM	0.32
10/24/2025	9:30:00 PM	0.32
10/24/2025	9:45:00 PM	0.32
10/24/2025	10:00:00 PM	0.32
10/24/2025	10:15:00 PM	0.32
10/24/2025	10:30:00 PM	0.32
10/24/2025	10:45:00 PM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
10/24/2025	11:00:00 PM	0.32
10/24/2025	11:15:00 PM	0.32
10/24/2025	11:30:00 PM	0.32
10/24/2025	11:45:00 PM	0.32
10/25/2025	12:00:00 AM	0.32
10/25/2025	12:15:00 AM	0.32
10/25/2025	12:30:00 AM	0.32
10/25/2025	12:45:00 AM	0.32
10/25/2025	1:00:00 AM	0.32
10/25/2025	1:15:00 AM	0.32
10/25/2025	1:30:00 AM	0.32
10/25/2025	1:45:00 AM	0.32
10/25/2025	2:00:00 AM	0.32
10/25/2025	2:15:00 AM	0.32
10/25/2025	2:30:00 AM	0.32
10/25/2025	2:45:00 AM	0.32
10/25/2025	3:00:00 AM	0.32
10/25/2025	3:15:00 AM	0.32
10/25/2025	3:30:00 AM	0.32
10/25/2025	3:45:00 AM	0.32
10/25/2025	4:00:00 AM	0.32
10/25/2025	4:15:00 AM	0.32
10/25/2025	4:30:00 AM	0.32
10/25/2025	4:45:00 AM	0.32
10/25/2025	5:00:00 AM	0.32
10/25/2025	5:15:00 AM	0.32
10/25/2025	5:30:00 AM	0.32
10/25/2025	5:45:00 AM	0.32
10/25/2025	6:00:00 AM	0.32
10/25/2025	6:15:00 AM	0.32
10/25/2025	6:30:00 AM	0.32
10/25/2025	6:45:00 AM	0.32
10/25/2025	7:00:00 AM	0.32
10/25/2025	7:15:00 AM	0.32
10/25/2025	7:30:00 AM	0.32
10/25/2025	7:45:00 AM	0.32
10/25/2025	8:00:00 AM	0.32
10/25/2025	8:15:00 AM	0.32
10/25/2025	8:30:00 AM	0.32
10/25/2025	8:45:00 AM	0.32
10/25/2025	9:00:00 AM	0.32
10/25/2025	9:15:00 AM	0.32
10/25/2025	9:30:00 AM	0.32
10/25/2025	9:45:00 AM	0.32
10/25/2025	10:00:00 AM	0.32
10/25/2025	10:15:00 AM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
10/25/2025	10:30:00 AM	0.32
10/25/2025	10:45:00 AM	0.32
10/25/2025	11:00:00 AM	0.32
10/25/2025	11:15:00 AM	0.32
10/25/2025	11:30:00 AM	0.32
10/25/2025	11:45:00 AM	0.32
10/25/2025	12:00:00 PM	0.32
10/25/2025	12:15:00 PM	0.32
10/25/2025	12:30:00 PM	0.32
10/25/2025	12:45:00 PM	0.32
10/25/2025	1:00:00 PM	0.32
10/25/2025	1:15:00 PM	0.32
10/25/2025	1:30:00 PM	0.32
10/25/2025	1:45:00 PM	0.32
10/25/2025	2:00:00 PM	0.32
10/25/2025	2:15:00 PM	0.32
10/25/2025	2:30:00 PM	0.32
10/25/2025	2:45:00 PM	0.32
10/25/2025	3:00:00 PM	0.32
10/25/2025	3:15:00 PM	0.32
10/25/2025	3:30:00 PM	0.32
10/25/2025	3:45:00 PM	0.32
10/25/2025	4:00:00 PM	0.32
10/25/2025	4:15:00 PM	0.32
10/25/2025	4:30:00 PM	0.32
10/25/2025	4:45:00 PM	0.32
10/25/2025	5:00:00 PM	0.32
10/25/2025	5:15:00 PM	0.32
10/25/2025	5:30:00 PM	0.32
10/25/2025	5:45:00 PM	0.32
10/25/2025	6:00:00 PM	0.32
10/25/2025	6:15:00 PM	0.32
10/25/2025	6:30:00 PM	0.32
10/25/2025	6:45:00 PM	0.32
10/25/2025	7:00:00 PM	0.32
10/25/2025	7:15:00 PM	0.32
10/25/2025	7:30:00 PM	0.32
10/25/2025	7:45:00 PM	0.32
10/25/2025	8:00:00 PM	0.32
10/25/2025	8:15:00 PM	0.32
10/25/2025	8:30:00 PM	0.32
10/25/2025	8:45:00 PM	0.32
10/25/2025	9:00:00 PM	0.32
10/25/2025	9:15:00 PM	0.32
10/25/2025	9:30:00 PM	0.32
10/25/2025	9:45:00 PM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
10/25/2025	10:00:00 PM	0.32
10/25/2025	10:15:00 PM	0.32
10/25/2025	10:30:00 PM	0.32
10/25/2025	10:45:00 PM	0.32
10/25/2025	11:00:00 PM	0.32
10/25/2025	11:15:00 PM	0.32
10/25/2025	11:30:00 PM	0.32
10/25/2025	11:45:00 PM	0.32
10/26/2025	12:00:00 AM	0.32
10/26/2025	12:15:00 AM	0.32
10/26/2025	12:30:00 AM	0.32
10/26/2025	12:45:00 AM	0.32
10/26/2025	1:00:00 AM	0.32
10/26/2025	1:15:00 AM	0.32
10/26/2025	1:30:00 AM	0.32
10/26/2025	1:45:00 AM	0.32
10/26/2025	2:00:00 AM	0.32
10/26/2025	2:15:00 AM	0.32
10/26/2025	2:30:00 AM	0.32
10/26/2025	2:45:00 AM	0.32
10/26/2025	3:00:00 AM	0.33
10/26/2025	3:15:00 AM	0.32
10/26/2025	3:30:00 AM	0.32
10/26/2025	3:45:00 AM	0.32
10/26/2025	4:00:00 AM	0.32
10/26/2025	4:15:00 AM	0.32
10/26/2025	4:30:00 AM	0.32
10/26/2025	4:45:00 AM	0.32
10/26/2025	5:00:00 AM	0.32
10/26/2025	5:15:00 AM	0.32
10/26/2025	5:30:00 AM	0.32
10/26/2025	5:45:00 AM	0.32
10/26/2025	6:00:00 AM	0.32
10/26/2025	6:15:00 AM	0.31
10/26/2025	6:30:00 AM	0.32
10/26/2025	6:45:00 AM	0.31
10/26/2025	7:00:00 AM	0.31
10/26/2025	7:15:00 AM	0.31
10/26/2025	7:30:00 AM	0.31
10/26/2025	7:45:00 AM	0.31
10/26/2025	8:00:00 AM	0.31
10/26/2025	8:15:00 AM	0.31
10/26/2025	8:30:00 AM	0.31
10/26/2025	8:45:00 AM	0.31
10/26/2025	9:00:00 AM	0.31
10/26/2025	9:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/26/2025	9:30:00 AM	0.31
10/26/2025	9:45:00 AM	0.31
10/26/2025	10:00:00 AM	0.31
10/26/2025	10:15:00 AM	0.31
10/26/2025	10:30:00 AM	0.31
10/26/2025	10:45:00 AM	0.31
10/26/2025	11:00:00 AM	0.31
10/26/2025	11:15:00 AM	0.31
10/26/2025	11:30:00 AM	0.31
10/26/2025	11:45:00 AM	0.31
10/26/2025	12:00:00 PM	0.31
10/26/2025	12:15:00 PM	0.31
10/26/2025	12:30:00 PM	0.31
10/26/2025	12:45:00 PM	0.31
10/26/2025	1:00:00 PM	0.31
10/26/2025	1:15:00 PM	0.31
10/26/2025	1:30:00 PM	0.31
10/26/2025	1:45:00 PM	0.31
10/26/2025	2:00:00 PM	0.31
10/26/2025	2:15:00 PM	0.31
10/26/2025	2:30:00 PM	0.31
10/26/2025	2:45:00 PM	0.31
10/26/2025	3:00:00 PM	0.31
10/26/2025	3:15:00 PM	0.31
10/26/2025	3:30:00 PM	0.31
10/26/2025	3:45:00 PM	0.31
10/26/2025	4:00:00 PM	0.31
10/26/2025	4:15:00 PM	0.31
10/26/2025	4:30:00 PM	0.31
10/26/2025	4:45:00 PM	0.31
10/26/2025	5:00:00 PM	0.31
10/26/2025	5:15:00 PM	0.31
10/26/2025	5:30:00 PM	0.31
10/26/2025	5:45:00 PM	0.31
10/26/2025	6:00:00 PM	0.31
10/26/2025	6:15:00 PM	0.31
10/26/2025	6:30:00 PM	0.31
10/26/2025	6:45:00 PM	0.31
10/26/2025	7:00:00 PM	0.31
10/26/2025	7:15:00 PM	0.31
10/26/2025	7:30:00 PM	0.31
10/26/2025	7:45:00 PM	0.31
10/26/2025	8:00:00 PM	0.31
10/26/2025	8:15:00 PM	0.31
10/26/2025	8:30:00 PM	0.31
10/26/2025	8:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/26/2025	9:00:00 PM	0.31
10/26/2025	9:15:00 PM	0.31
10/26/2025	9:30:00 PM	0.31
10/26/2025	9:45:00 PM	0.31
10/26/2025	10:00:00 PM	0.31
10/26/2025	10:15:00 PM	0.31
10/26/2025	10:30:00 PM	0.31
10/26/2025	10:45:00 PM	0.31
10/26/2025	11:00:00 PM	0.31
10/26/2025	11:15:00 PM	0.31
10/26/2025	11:30:00 PM	0.31
10/26/2025	11:45:00 PM	0.31
10/27/2025	12:00:00 AM	0.31
10/27/2025	12:15:00 AM	0.31
10/27/2025	12:30:00 AM	0.31
10/27/2025	12:45:00 AM	0.31
10/27/2025	1:00:00 AM	0.31
10/27/2025	1:15:00 AM	0.31
10/27/2025	1:30:00 AM	0.31
10/27/2025	1:45:00 AM	0.31
10/27/2025	2:00:00 AM	0.31
10/27/2025	2:15:00 AM	0.31
10/27/2025	2:30:00 AM	0.31
10/27/2025	2:45:00 AM	0.31
10/27/2025	3:00:00 AM	0.31
10/27/2025	3:15:00 AM	0.31
10/27/2025	3:30:00 AM	0.31
10/27/2025	3:45:00 AM	0.31
10/27/2025	4:00:00 AM	0.31
10/27/2025	4:15:00 AM	0.31
10/27/2025	4:30:00 AM	0.31
10/27/2025	4:45:00 AM	0.31
10/27/2025	5:00:00 AM	0.31
10/27/2025	5:15:00 AM	0.31
10/27/2025	5:30:00 AM	0.31
10/27/2025	5:45:00 AM	0.31
10/27/2025	6:00:00 AM	0.31
10/27/2025	6:15:00 AM	0.31
10/27/2025	6:30:00 AM	0.31
10/27/2025	6:45:00 AM	0.31
10/27/2025	7:00:00 AM	0.31
10/27/2025	7:15:00 AM	0.31
10/27/2025	7:30:00 AM	0.31
10/27/2025	7:45:00 AM	0.31
10/27/2025	8:00:00 AM	0.31
10/27/2025	8:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/27/2025	8:30:00 AM	0.31
10/27/2025	8:45:00 AM	0.31
10/27/2025	9:00:00 AM	0.31
10/27/2025	9:15:00 AM	0.31
10/27/2025	9:30:00 AM	0.31
10/27/2025	9:45:00 AM	0.31
10/27/2025	10:00:00 AM	0.31
10/27/2025	10:15:00 AM	0.31
10/27/2025	10:30:00 AM	0.31
10/27/2025	10:45:00 AM	0.31
10/27/2025	11:00:00 AM	0.31
10/27/2025	11:15:00 AM	0.31
10/27/2025	11:30:00 AM	0.31
10/27/2025	11:45:00 AM	0.31
10/27/2025	12:00:00 PM	0.31
10/27/2025	12:15:00 PM	0.31
10/27/2025	12:30:00 PM	0.31
10/27/2025	12:45:00 PM	0.31
10/27/2025	1:00:00 PM	0.31
10/27/2025	1:15:00 PM	0.31
10/27/2025	1:30:00 PM	0.31
10/27/2025	1:45:00 PM	0.31
10/27/2025	2:00:00 PM	0.31
10/27/2025	2:15:00 PM	0.31
10/27/2025	2:30:00 PM	0.31
10/27/2025	2:45:00 PM	0.31
10/27/2025	3:00:00 PM	0.31
10/27/2025	3:15:00 PM	0.31
10/27/2025	3:30:00 PM	0.31
10/27/2025	3:45:00 PM	0.31
10/27/2025	4:00:00 PM	0.31
10/27/2025	4:15:00 PM	0.31
10/27/2025	4:30:00 PM	0.31
10/27/2025	4:45:00 PM	0.31
10/27/2025	5:00:00 PM	0.31
10/27/2025	5:15:00 PM	0.31
10/27/2025	5:30:00 PM	0.31
10/27/2025	5:45:00 PM	0.31
10/27/2025	6:00:00 PM	0.31
10/27/2025	6:15:00 PM	0.31
10/27/2025	6:30:00 PM	0.31
10/27/2025	6:45:00 PM	0.31
10/27/2025	7:00:00 PM	0.31
10/27/2025	7:15:00 PM	0.31
10/27/2025	7:30:00 PM	0.31
10/27/2025	7:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/27/2025	8:00:00 PM	0.31
10/27/2025	8:15:00 PM	0.31
10/27/2025	8:30:00 PM	0.31
10/27/2025	8:45:00 PM	0.31
10/27/2025	9:00:00 PM	0.31
10/27/2025	9:15:00 PM	0.31
10/27/2025	9:30:00 PM	0.31
10/27/2025	9:45:00 PM	0.31
10/27/2025	10:00:00 PM	0.31
10/27/2025	10:15:00 PM	0.31
10/27/2025	10:30:00 PM	0.31
10/27/2025	10:45:00 PM	0.32
10/27/2025	11:00:00 PM	0.31
10/27/2025	11:15:00 PM	0.31
10/27/2025	11:30:00 PM	0.31
10/27/2025	11:45:00 PM	0.31
10/28/2025	12:00:00 AM	0.31
10/28/2025	12:15:00 AM	0.31
10/28/2025	12:30:00 AM	0.31
10/28/2025	12:45:00 AM	0.31
10/28/2025	1:00:00 AM	0.31
10/28/2025	1:15:00 AM	0.31
10/28/2025	1:30:00 AM	0.31
10/28/2025	1:45:00 AM	0.3
10/28/2025	2:00:00 AM	0.3
10/28/2025	2:15:00 AM	0.31
10/28/2025	2:30:00 AM	0.31
10/28/2025	2:45:00 AM	0.31
10/28/2025	3:00:00 AM	0.31
10/28/2025	3:15:00 AM	0.3
10/28/2025	3:30:00 AM	0.3
10/28/2025	3:45:00 AM	0.31
10/28/2025	4:00:00 AM	0.3
10/28/2025	4:15:00 AM	0.3
10/28/2025	4:30:00 AM	0.3
10/28/2025	4:45:00 AM	0.3
10/28/2025	5:00:00 AM	0.3
10/28/2025	5:15:00 AM	0.3
10/28/2025	5:30:00 AM	0.31
10/28/2025	5:45:00 AM	0.3
10/28/2025	6:00:00 AM	0.3
10/28/2025	6:15:00 AM	0.3
10/28/2025	6:30:00 AM	0.3
10/28/2025	6:45:00 AM	0.3
10/28/2025	7:00:00 AM	0.3
10/28/2025	7:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
10/28/2025	7:30:00 AM	0.3
10/28/2025	7:45:00 AM	0.3
10/28/2025	8:00:00 AM	0.3
10/28/2025	8:15:00 AM	0.3
10/28/2025	8:30:00 AM	0.3
10/28/2025	8:45:00 AM	0.3
10/28/2025	9:00:00 AM	0.3
10/28/2025	9:15:00 AM	0.3
10/28/2025	9:30:00 AM	0.3
10/28/2025	9:45:00 AM	0.3
10/28/2025	10:00:00 AM	0.3
10/28/2025	10:15:00 AM	0.3
10/28/2025	10:30:00 AM	0.3
10/28/2025	10:45:00 AM	0.3
10/28/2025	11:00:00 AM	0.3
10/28/2025	11:15:00 AM	0.3
10/28/2025	11:30:00 AM	0.3
10/28/2025	11:45:00 AM	0.3
10/28/2025	12:00:00 PM	0.3
10/28/2025	12:15:00 PM	0.3
10/28/2025	12:30:00 PM	0.3
10/28/2025	12:45:00 PM	0.3
10/28/2025	1:00:00 PM	0.3
10/28/2025	1:15:00 PM	0.3
10/28/2025	1:30:00 PM	0.3
10/28/2025	1:45:00 PM	0.3
10/28/2025	2:00:00 PM	0.3
10/28/2025	2:15:00 PM	0.3
10/28/2025	2:30:00 PM	0.3
10/28/2025	2:45:00 PM	0.3
10/28/2025	3:00:00 PM	0.3
10/28/2025	3:15:00 PM	0.3
10/28/2025	3:30:00 PM	0.3
10/28/2025	3:45:00 PM	0.3
10/28/2025	4:00:00 PM	0.3
10/28/2025	4:15:00 PM	0.3
10/28/2025	4:30:00 PM	0.3
10/28/2025	4:45:00 PM	0.3
10/28/2025	5:00:00 PM	0.3
10/28/2025	5:15:00 PM	0.3
10/28/2025	5:30:00 PM	0.3
10/28/2025	5:45:00 PM	0.3
10/28/2025	6:00:00 PM	0.3
10/28/2025	6:15:00 PM	0.3
10/28/2025	6:30:00 PM	0.3
10/28/2025	6:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
10/28/2025	7:00:00 PM	0.3
10/28/2025	7:15:00 PM	0.3
10/28/2025	7:30:00 PM	0.3
10/28/2025	7:45:00 PM	0.3
10/28/2025	8:00:00 PM	0.3
10/28/2025	8:15:00 PM	0.3
10/28/2025	8:30:00 PM	0.3
10/28/2025	8:45:00 PM	0.3
10/28/2025	9:00:00 PM	0.3
10/28/2025	9:15:00 PM	0.3
10/28/2025	9:30:00 PM	0.3
10/28/2025	9:45:00 PM	0.3
10/28/2025	10:00:00 PM	0.3
10/28/2025	10:15:00 PM	0.3
10/28/2025	10:30:00 PM	0.3
10/28/2025	10:45:00 PM	0.3
10/28/2025	11:00:00 PM	0.3
10/28/2025	11:15:00 PM	0.3
10/28/2025	11:30:00 PM	0.3
10/28/2025	11:45:00 PM	0.3
10/29/2025	12:00:00 AM	0.3
10/29/2025	12:15:00 AM	0.3
10/29/2025	12:30:00 AM	0.3
10/29/2025	12:45:00 AM	0.3
10/29/2025	1:00:00 AM	0.3
10/29/2025	1:15:00 AM	0.3
10/29/2025	1:30:00 AM	0.3
10/29/2025	1:45:00 AM	0.3
10/29/2025	2:00:00 AM	0.3
10/29/2025	2:15:00 AM	0.3
10/29/2025	2:30:00 AM	0.3
10/29/2025	2:45:00 AM	0.3
10/29/2025	3:00:00 AM	0.3
10/29/2025	3:15:00 AM	0.3
10/29/2025	3:30:00 AM	0.3
10/29/2025	3:45:00 AM	0.3
10/29/2025	4:00:00 AM	0.3
10/29/2025	4:15:00 AM	0.3
10/29/2025	4:30:00 AM	0.3
10/29/2025	4:45:00 AM	0.3
10/29/2025	5:00:00 AM	0.3
10/29/2025	5:15:00 AM	0.3
10/29/2025	5:30:00 AM	0.3
10/29/2025	5:45:00 AM	0.3
10/29/2025	6:00:00 AM	0.3
10/29/2025	6:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
10/29/2025	6:30:00 AM	0.3
10/29/2025	6:45:00 AM	0.3
10/29/2025	7:00:00 AM	0.3
10/29/2025	7:15:00 AM	0.3
10/29/2025	7:30:00 AM	0.3
10/29/2025	7:45:00 AM	0.3
10/29/2025	8:00:00 AM	0.3
10/29/2025	8:15:00 AM	0.3
10/29/2025	8:30:00 AM	0.3
10/29/2025	8:45:00 AM	0.3
10/29/2025	9:00:00 AM	0.3
10/29/2025	9:15:00 AM	0.3
10/29/2025	9:30:00 AM	0.29
10/29/2025	9:45:00 AM	0.29
10/29/2025	10:00:00 AM	0.29
10/29/2025	10:15:00 AM	0.29
10/29/2025	10:30:00 AM	0.29
10/29/2025	10:45:00 AM	0.29
10/29/2025	11:00:00 AM	0.29
10/29/2025	11:15:00 AM	0.29
10/29/2025	11:30:00 AM	0.29
10/29/2025	11:45:00 AM	0.29
10/29/2025	12:00:00 PM	0.29
10/29/2025	12:15:00 PM	0.29
10/29/2025	12:30:00 PM	0.29
10/29/2025	12:45:00 PM	0.29
10/29/2025	1:00:00 PM	0.29
10/29/2025	1:15:00 PM	0.29
10/29/2025	1:30:00 PM	0.29
10/29/2025	1:45:00 PM	0.28
10/29/2025	2:00:00 PM	0.27
10/29/2025	2:15:00 PM	0.27
10/29/2025	2:30:00 PM	0.26
10/29/2025	2:45:00 PM	0.25
10/29/2025	3:00:00 PM	0.25
10/29/2025	3:15:00 PM	0.24
10/29/2025	3:30:00 PM	0.24
10/29/2025	3:45:00 PM	0.23
10/29/2025	4:00:00 PM	0.23
10/29/2025	4:15:00 PM	0.22
10/29/2025	4:30:00 PM	0.22
10/29/2025	4:45:00 PM	0.21
10/29/2025	5:00:00 PM	0.21
10/29/2025	5:15:00 PM	0.21
10/29/2025	5:30:00 PM	0.2
10/29/2025	5:45:00 PM	0.2

Billy Lake Return Gage

DATE	TIME	GAGE
10/29/2025	6:00:00 PM	0.2
10/29/2025	6:15:00 PM	0.19
10/29/2025	6:30:00 PM	0.19
10/29/2025	6:45:00 PM	0.19
10/29/2025	7:00:00 PM	0.18
10/29/2025	7:15:00 PM	0.18
10/29/2025	7:30:00 PM	0.18
10/29/2025	7:45:00 PM	0.18
10/29/2025	8:00:00 PM	0.17
10/29/2025	8:15:00 PM	0.17
10/29/2025	8:30:00 PM	0.17
10/29/2025	8:45:00 PM	0.17
10/29/2025	9:00:00 PM	0.17
10/29/2025	9:15:00 PM	0.16
10/29/2025	9:30:00 PM	0.16
10/29/2025	9:45:00 PM	0.16
10/29/2025	10:00:00 PM	0.16
10/29/2025	10:15:00 PM	0.16
10/29/2025	10:30:00 PM	0.16
10/29/2025	10:45:00 PM	0.15
10/29/2025	11:00:00 PM	0.15
10/29/2025	11:15:00 PM	0.15
10/29/2025	11:30:00 PM	0.15
10/29/2025	11:45:00 PM	0.15
10/30/2025	12:00:00 AM	0.15
10/30/2025	12:15:00 AM	0.15
10/30/2025	12:30:00 AM	0.15
10/30/2025	12:45:00 AM	0.15
10/30/2025	1:00:00 AM	0.14
10/30/2025	1:15:00 AM	0.14
10/30/2025	1:30:00 AM	0.14
10/30/2025	1:45:00 AM	0.14
10/30/2025	2:00:00 AM	0.14
10/30/2025	2:15:00 AM	0.14
10/30/2025	2:30:00 AM	0.14
10/30/2025	2:45:00 AM	0.14
10/30/2025	3:00:00 AM	0.14
10/30/2025	3:15:00 AM	0.14
10/30/2025	3:30:00 AM	0.14
10/30/2025	3:45:00 AM	0.13
10/30/2025	4:00:00 AM	0.13
10/30/2025	4:15:00 AM	0.13
10/30/2025	4:30:00 AM	0.13
10/30/2025	4:45:00 AM	0.13
10/30/2025	5:00:00 AM	0.13
10/30/2025	5:15:00 AM	0.13

Billy Lake Return Gage

DATE	TIME	GAGE
10/30/2025	5:30:00 AM	0.13
10/30/2025	5:45:00 AM	0.13
10/30/2025	6:00:00 AM	0.13
10/30/2025	6:15:00 AM	0.13
10/30/2025	6:30:00 AM	0.14
10/30/2025	6:45:00 AM	0.14
10/30/2025	7:00:00 AM	0.15
10/30/2025	7:15:00 AM	0.16
10/30/2025	7:30:00 AM	0.16
10/30/2025	7:45:00 AM	0.17
10/30/2025	8:00:00 AM	0.18
10/30/2025	8:15:00 AM	0.18
10/30/2025	8:30:00 AM	0.19
10/30/2025	8:45:00 AM	0.19
10/30/2025	9:00:00 AM	0.2
10/30/2025	9:15:00 AM	0.2
10/30/2025	9:30:00 AM	0.21
10/30/2025	9:45:00 AM	0.21
10/30/2025	10:00:00 AM	0.22
10/30/2025	10:15:00 AM	0.22
10/30/2025	10:30:00 AM	0.23
10/30/2025	10:45:00 AM	0.23
10/30/2025	11:00:00 AM	0.23
10/30/2025	11:15:00 AM	0.24
10/30/2025	11:30:00 AM	0.24
10/30/2025	11:45:00 AM	0.25
10/30/2025	12:00:00 PM	0.25
10/30/2025	12:15:00 PM	0.25
10/30/2025	12:30:00 PM	0.26
10/30/2025	12:45:00 PM	0.26
10/30/2025	1:00:00 PM	0.26
10/30/2025	1:15:00 PM	0.27
10/30/2025	1:30:00 PM	0.27
10/30/2025	1:45:00 PM	0.27
10/30/2025	2:00:00 PM	0.27
10/30/2025	2:15:00 PM	0.27
10/30/2025	2:30:00 PM	0.27
10/30/2025	2:45:00 PM	0.28
10/30/2025	3:00:00 PM	0.28
10/30/2025	3:15:00 PM	0.28
10/30/2025	3:30:00 PM	0.28
10/30/2025	3:45:00 PM	0.28
10/30/2025	4:00:00 PM	0.29
10/30/2025	4:15:00 PM	0.29
10/30/2025	4:30:00 PM	0.29
10/30/2025	4:45:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
10/30/2025	5:00:00 PM	0.29
10/30/2025	5:15:00 PM	0.29
10/30/2025	5:30:00 PM	0.29
10/30/2025	5:45:00 PM	0.29
10/30/2025	6:00:00 PM	0.29
10/30/2025	6:15:00 PM	0.29
10/30/2025	6:30:00 PM	0.29
10/30/2025	6:45:00 PM	0.3
10/30/2025	7:00:00 PM	0.3
10/30/2025	7:15:00 PM	0.3
10/30/2025	7:30:00 PM	0.3
10/30/2025	7:45:00 PM	0.3
10/30/2025	8:00:00 PM	0.3
10/30/2025	8:15:00 PM	0.3
10/30/2025	8:30:00 PM	0.31
10/30/2025	8:45:00 PM	0.3
10/30/2025	9:00:00 PM	0.3
10/30/2025	9:15:00 PM	0.3
10/30/2025	9:30:00 PM	0.3
10/30/2025	9:45:00 PM	0.3
10/30/2025	10:00:00 PM	0.3
10/30/2025	10:15:00 PM	0.3
10/30/2025	10:30:00 PM	0.3
10/30/2025	10:45:00 PM	0.3
10/30/2025	11:00:00 PM	0.3
10/30/2025	11:15:00 PM	0.3
10/30/2025	11:30:00 PM	0.3
10/30/2025	11:45:00 PM	0.3
10/31/2025	12:00:00 AM	0.3
10/31/2025	12:15:00 AM	0.3
10/31/2025	12:30:00 AM	0.3
10/31/2025	12:45:00 AM	0.3
10/31/2025	1:00:00 AM	0.3
10/31/2025	1:15:00 AM	0.3
10/31/2025	1:30:00 AM	0.3
10/31/2025	1:45:00 AM	0.3
10/31/2025	2:00:00 AM	0.31
10/31/2025	2:15:00 AM	0.3
10/31/2025	2:30:00 AM	0.3
10/31/2025	2:45:00 AM	0.31
10/31/2025	3:00:00 AM	0.31
10/31/2025	3:15:00 AM	0.3
10/31/2025	3:30:00 AM	0.31
10/31/2025	3:45:00 AM	0.31
10/31/2025	4:00:00 AM	0.31
10/31/2025	4:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/31/2025	4:30:00 AM	0.31
10/31/2025	4:45:00 AM	0.31
10/31/2025	5:00:00 AM	0.31
10/31/2025	5:15:00 AM	0.31
10/31/2025	5:30:00 AM	0.31
10/31/2025	5:45:00 AM	0.31
10/31/2025	6:00:00 AM	0.31
10/31/2025	6:15:00 AM	0.31
10/31/2025	6:30:00 AM	0.3
10/31/2025	6:45:00 AM	0.31
10/31/2025	7:00:00 AM	0.31
10/31/2025	7:15:00 AM	0.31
10/31/2025	7:30:00 AM	0.31
10/31/2025	7:45:00 AM	0.31
10/31/2025	8:00:00 AM	0.31
10/31/2025	8:15:00 AM	0.31
10/31/2025	8:30:00 AM	0.31
10/31/2025	8:45:00 AM	0.31
10/31/2025	9:00:00 AM	0.31
10/31/2025	9:15:00 AM	0.31
10/31/2025	9:30:00 AM	0.31
10/31/2025	9:45:00 AM	0.31
10/31/2025	10:00:00 AM	0.31
10/31/2025	10:15:00 AM	0.31
10/31/2025	10:30:00 AM	0.31
10/31/2025	10:45:00 AM	0.31
10/31/2025	11:00:00 AM	0.3
10/31/2025	11:15:00 AM	0.31
10/31/2025	11:30:00 AM	0.31
10/31/2025	11:45:00 AM	0.3
10/31/2025	12:00:00 PM	0.31
10/31/2025	12:15:00 PM	0.31
10/31/2025	12:30:00 PM	0.31
10/31/2025	12:45:00 PM	0.31
10/31/2025	1:00:00 PM	0.3
10/31/2025	1:15:00 PM	0.31
10/31/2025	1:30:00 PM	0.31
10/31/2025	1:45:00 PM	0.31
10/31/2025	2:00:00 PM	0.31
10/31/2025	2:15:00 PM	0.31
10/31/2025	2:30:00 PM	0.31
10/31/2025	2:45:00 PM	0.31
10/31/2025	3:00:00 PM	0.3
10/31/2025	3:15:00 PM	0.31
10/31/2025	3:30:00 PM	0.31
10/31/2025	3:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
10/31/2025	4:00:00 PM	0.31
10/31/2025	4:15:00 PM	0.31
10/31/2025	4:30:00 PM	0.31
10/31/2025	4:45:00 PM	0.31
10/31/2025	5:00:00 PM	0.3
10/31/2025	5:15:00 PM	0.3
10/31/2025	5:30:00 PM	0.3
10/31/2025	5:45:00 PM	0.3
10/31/2025	6:00:00 PM	0.3
10/31/2025	6:15:00 PM	0.3
10/31/2025	6:30:00 PM	0.3
10/31/2025	6:45:00 PM	0.3
10/31/2025	7:00:00 PM	0.3
10/31/2025	7:15:00 PM	0.3
10/31/2025	7:30:00 PM	0.3
10/31/2025	7:45:00 PM	0.3
10/31/2025	8:00:00 PM	0.3
10/31/2025	8:15:00 PM	0.3
10/31/2025	8:30:00 PM	0.3
10/31/2025	8:45:00 PM	0.3
10/31/2025	9:00:00 PM	0.3
10/31/2025	9:15:00 PM	0.3
10/31/2025	9:30:00 PM	0.3
10/31/2025	9:45:00 PM	0.3
10/31/2025	10:00:00 PM	0.3
10/31/2025	10:15:00 PM	0.3
10/31/2025	10:30:00 PM	0.3
10/31/2025	10:45:00 PM	0.3
10/31/2025	11:00:00 PM	0.3
10/31/2025	11:15:00 PM	0.3
10/31/2025	11:30:00 PM	0.3
10/31/2025	11:45:00 PM	0.3

Party: BLP BRP	Width: 20.4 ft	Processed by: BJA
Boat/Motor: BOAT	Area: 70.4 ft ²	Mean Velocity: 0.791 ft/s
Gage Height: 3.37 ft	G.H.Change: 0.000 ft	Discharge: 55.6 ft ³ /s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.00°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft ²	Diff.: 0.000%
Depth: Composite (BT)	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:		ADCP:	
BT 3-Beam Solution: YES	Max. Vel.: 2.50 ft/s	Type/Freq.: StreamPro / 2000 kHz	
WT 3-Beam Solution: YES	Max. Depth: 3.53 ft	Serial #: 2370	Firmware: 31.17
BT Error Vel.: 0.33 ft/s	Mean Depth: 3.45 ft	Bin Size: 4 cm	Blank: 3 cm
WT Error Vel.: 1.41 ft/s	% Meas.: 63.35	BT Mode: 10	BT Pings: 2
BT Up Vel.: 1.00 ft/s	Water Temp.: None	WT Mode: 12	WT Pings: 6
WT Up Vel.: 1.64 ft/s	ADCP Temp.: 62.1 °F		
Use Weighted Mean Depth: YES			

Performed Diag. Test: NO
 Performed Moving Bed Test: NO
 Performed Compass Calibration: NO Evaluation: NO
 Meas. Location: BRIDGE

Project Name: 251028 MOUK_0.mmt
 Software: 2.26.00.04

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	L	2	0	30	7.66	37.1	5.26	4.27	0.000	54.3	19	66	09:18	09:19	0.55	0.82	0	0
001	R	2	2	35	7.24	34.9	5.09	4.91	4.84	56.9	20	71	09:19	09:19	0.44	0.80	0	2
002	L	2	2	29	7.38	35.6	4.84	4.41	4.98	57.2	21	72	09:19	09:20	0.56	0.80	0	1
003	R	2	2	30	6.92	33.5	4.73	4.70	4.34	54.1	21	73	09:20	09:21	0.54	0.74	0	1
Mean		2	2	31	7.30	35.3	4.98	4.57	3.54	55.6	20	70	Total	00:03	0.52	0.79	0	1
SDev		0	1	3	0.308	1.50	0.240	0.285	2.38	1.64	0.9	3.0			0.06	0.03		
SD/M		0.0%	66.7%	8.7%	4.2%	4.3%	4.8%	6.2%	67.1%	2.9%	4.4%	4.2%			10.5%	4.3%		

Remarks:

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	1	0	3	31	33	-0.4	1.081	0.4	0.3	0	53.3	54.6	0	150	153	0	26	26
2025	10	1	0	13	31	34.4	-1.9	1.081	0.4	0.3	0	52.9	54.2	0	150	153	0	27	27
2025	10	1	0	23	31	32.6	-1.8	1.082	0.4	0.3	0	52.9	54.6	0	149	153	0	26	26
2025	10	1	0	33	31	33.8	-1.1	1.082	0.3	0.2	0	53.3	54.6	0	150	153	0	26	26
2025	10	1	0	43	31	34.1	-1.7	1.082	0.4	0.3	0	53.3	54.6	0	150	153	0	26	26
2025	10	1	0	53	31	34.1	-1.1	1.082	0.4	0.3	0	52.9	54.2	0	149	153	0	26	27
2025	10	1	1	3	31	33.7	-1.3	1.083	0.4	0.3	0	52.9	54.2	0	149	153	0	26	27
2025	10	1	1	13	31	34.7	-1.5	1.082	0.3	0.2	0	52.9	54.2	0	149	153	0	26	27
2025	10	1	1	23	31	33.2	-1.8	1.083	0.3	0.2	0	52.9	54.2	0	149	153	0	26	27
2025	10	1	1	33	31	34.2	-1.3	1.083	0.4	0.3	0	52.9	54.6	0	149	153	0	26	26
2025	10	1	1	43	31	33.4	-0.9	1.083	0.3	0.2	0	52.9	54.6	0	149	153	0	26	26
2025	10	1	1	53	31	32.6	-1.1	1.083	0.5	0.4	0	53.3	54.2	0	150	153	0	26	27
2025	10	1	2	3	31	33.8	-0.4	1.083	0.5	0.5	0	52.9	54.6	0	149	153	0	26	26
2025	10	1	2	13	31	33.6	-1.6	1.083	0.4	0.3	0	52	54.6	0	148	153	0	27	26
2025	10	1	2	23	31	33.4	-0.8	1.083	0.5	0.4	0	52.5	54.2	0	149	153	0	27	27
2025	10	1	2	33	31	32.8	-1.4	1.083	0.4	0.3	0	52.9	54.2	0	149	153	0	26	27
2025	10	1	2	43	31	32.9	-0.4	1.083	0.5	0.4	0	52.5	54.6	0	149	153	0	27	26
2025	10	1	2	53	31	33.2	-0.8	1.083	0.5	0.5	0	53.3	54.6	0	150	154	0	26	27
2025	10	1	3	3	31	34.9	-1.3	1.084	0.5	0.4	0	52.9	54.2	0	149	153	0	26	27
2025	10	1	3	13	31	33.6	-0.9	1.084	0.4	0.3	0	52.5	54.2	0	149	153	0	27	27
2025	10	1	3	23	31	33.5	-2	1.084	0.4	0.3	0	52.9	54.6	0	149	153	0	26	26
2025	10	1	3	33	31	34.1	-0.9	1.084	0.5	0.4	0	52.9	54.6	0	149	153	0	26	26
2025	10	1	3	43	31	33.7	-1.7	1.084	0.4	0.3	0	52.9	54.6	0	149	153	0	26	26
2025	10	1	3	53	31	33.4	-1.3	1.084	0.4	0.3	0	52.5	54.6	0	149	153	0	27	26
2025	10	1	4	3	31	34	-1.7	1.084	0.5	0.4	0	55	55	0	154	154	0	26	26
2025	10	1	4	13	31	33.1	-0.8	1.084	0.5	0.4	0	55	54.2	0	154	153	0	26	27
2025	10	1	4	23	31	33.1	-1.8	1.085	0.4	0.3	0	55	54.6	0	154	153	0	26	26
2025	10	1	4	33	31	34	-1.4	1.085	0.4	0.3	0	54.2	54.6	0	153	153	0	27	26
2025	10	1	4	43	31	34.5	0	1.085	0.4	0.3	0	54.6	54.2	0	153	153	0	26	27
2025	10	1	4	53	31	34.4	-2.5	1.085	0.4	0.3	0	54.6	54.2	0	153	153	0	26	27
2025	10	1	5	3	31	34.4	-1.4	1.085	0.4	0.3	0	54.2	54.2	0	153	153	0	27	27
2025	10	1	5	13	31	34.4	-1.3	1.085	0.5	0.4	0	54.6	54.6	0	153	154	0	26	27
2025	10	1	5	23	31	33.6	-1.3	1.085	0.4	0.3	0	55	55	0	154	154	0	26	26
2025	10	1	5	33	31	33.3	-1.3	1.086	0.3	0.2	0	54.2	54.6	0	153	154	0	27	27
2025	10	1	5	43	31	33.8	-1.2	1.087	0.3	0.2	0	54.2	54.6	0	153	154	0	27	27
2025	10	1	5	53	31	33.9	-2	1.088	0.5	0.4	0	54.2	54.2	0	153	153	0	27	27
2025	10	1	6	3	31	33.9	-0.9	1.088	0.5	0.4	0	54.6	54.6	0	153	154	0	26	27
2025	10	1	6	13	31	32.9	-1.4	1.089	0.4	0.3	0	54.2	54.6	0	153	154	0	27	27
2025	10	1	6	23	31	33.9	-0.7	1.09	0.4	0.3	0	54.6	54.6	0	153	154	0	26	27
2025	10	1	6	33	31	33.9	-1.3	1.09	0.4	0.3	0	54.2	54.2	0	153	153	0	27	27
2025	10	1	6	43	31	34.3	-0.8	1.09	0.4	0.3	0	54.2	55	0	153	154	0	27	26
2025	10	1	6	53	31	34.2	-1.1	1.09	0.4	0.3	0	54.2	54.6	0	153	154	0	27	27
2025	10	1	7	3	31	34	-1.7	1.091	0.5	0.4	0	54.6	54.2	0	153	153	0	26	27
2025	10	1	7	13	31	33.8	-0.9	1.091	0.3	0.2	0	54.6	54.6	0	153	154	0	26	27
2025	10	1	7	23	31	33.4	-1.2	1.091	0.5	0.4	0	54.6	54.2	0	153	153	0	26	27
2025	10	1	7	33	31	33.8	-1.6	1.091	0.4	0.3	0	53.8	53.8	0	152	153	0	27	28
2025	10	1	7	43	31	33.9	-1.3	1.091	0.3	0.2	0	54.2	54.2	0	152	153	0	26	27
2025	10	1	7	53	31	34.1	-0.8	1.091	0.5	0.5	0	54.2	54.2	0	152	153	0	26	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	1	8	3	31	34.1	-2	1.091	0.5	0.4	0	54.2	54.6	0	152	153	0	26	26
2025	10	1	8	13	31	33.8	-1.2	1.092	0.4	0.3	0	53.8	54.2	0	152	153	0	27	27
2025	10	1	8	23	31	34	0	1.092	0.4	0.3	0	54.2	54.6	0	152	153	0	26	26
2025	10	1	8	33	31	33.2	-0.8	1.092	0.4	0.3	0	53.3	53.8	0	151	152	0	27	27
2025	10	1	8	43	31	34.5	-1.7	1.092	0.5	0.4	0	53.8	53.8	0	151	152	0	26	27
2025	10	1	8	53	31	34.4	-1	1.092	0.3	0.2	0	52.9	53.3	0	150	151	0	27	27
2025	10	1	9	3	31	34	-0.6	1.092	0.5	0.4	0	52.9	53.3	0	150	151	0	27	27
2025	10	1	9	13	31	34.1	-1.3	1.092	0.3	0.2	0	52.9	53.3	0	150	151	0	27	27
2025	10	1	9	23	31	34.2	-1.3	1.092	0.5	0.4	0	52.9	52.9	0	149	150	0	26	27
2025	10	1	9	33	31	33.9	-1.5	1.092	0.4	0.3	0	52.9	52.9	0	149	150	0	26	27
2025	10	1	9	43	31	34.9	-2.3	1.092	0.3	0.2	0	52	52.9	0	148	150	0	27	27
2025	10	1	9	53	31	34	-1.1	1.092	0.5	0.4	0	52.5	52.9	0	149	150	0	27	27
2025	10	1	10	3	31	34	-1.7	1.093	0.4	0.3	0	52	52.9	0	148	150	0	27	27
2025	10	1	10	13	31	33.8	-1.3	1.093	0.5	0.4	0	52.5	52.5	0	148	149	0	26	27
2025	10	1	10	23	31	34.1	-1.5	1.093	0.4	0.3	0	52	52.5	0	148	149	0	27	27
2025	10	1	10	33	31	34.2	-2.1	1.093	0.4	0.3	0	52	52.5	0	147	149	0	26	27
2025	10	1	10	43	31	33.4	-1.2	1.093	0.4	0.3	0	51.6	52.5	0	147	149	0	27	27
2025	10	1	10	53	31	32.6	-1.3	1.093	0.4	0.3	0	52.9	52.9	0	149	149	0	26	26
2025	10	1	11	3	31	33.6	-1.7	1.093	0.3	0.2	0	52.9	52	0	149	148	0	26	27
2025	10	1	11	13	31	34.3	-1.8	1.093	0.4	0.3	0	52.5	52	0	149	148	0	27	27
2025	10	1	11	23	31	33.1	-1.6	1.094	0.3	0.2	0	53.3	52.5	0	150	149	0	26	27
2025	10	1	11	33	31	33.6	-1.2	1.094	0.5	0.4	0	52.9	52.5	0	150	149	0	27	27
2025	10	1	11	43	31	33.9	-1.1	1.094	0.5	0.4	0	52.5	52.5	0	149	149	0	27	27
2025	10	1	11	53	31	33.6	-2	1.094	0.5	0.4	0	52.9	52.5	0	149	149	0	26	27
2025	10	1	12	3	31	34.2	-2.1	1.094	0.4	0.3	0	52.9	52	0	149	148	0	26	27
2025	10	1	12	13	31	34.2	-1.9	1.094	0.5	0.4	0	52.5	52	0	149	148	0	27	27
2025	10	1	12	23	31	33.6	-1.1	1.094	0.5	0.4	0	53.3	52.9	0	150	149	0	26	26
2025	10	1	12	33	31	34.4	-2.4	1.094	0.4	0.3	0	52.9	52.5	0	149	149	0	26	27
2025	10	1	12	43	31	34.5	-1.1	1.094	0.4	0.3	0	52.5	52.9	0	149	149	0	27	26
2025	10	1	12	53	31	35.2	-1.7	1.094	0.5	0.4	0	52	52	0	148	148	0	27	27
2025	10	1	13	3	31	34.4	-2.4	1.095	0.5	0.4	0	52.5	52	0	148	148	0	26	27
2025	10	1	13	13	31	33.7	-0.4	1.095	0.4	0.3	0	52	52	0	148	148	0	27	27
2025	10	1	13	23	31	34	-0.7	1.095	0.3	0.2	0	52.9	52	0	149	148	0	26	27
2025	10	1	13	33	31	33.4	-1.9	1.095	0.5	0.4	0	52.5	52	0	148	148	0	26	27
2025	10	1	13	43	31	34.7	-0.4	1.094	0.4	0.3	0	52	52	0	148	148	0	27	27
2025	10	1	13	53	31	34.5	-0.5	1.094	0.5	0.4	0	52	52	0	147	148	0	26	27
2025	10	1	14	3	31	33.9	-1.5	1.094	0.4	0.3	0	52.5	52.5	0	148	148	0	26	26
2025	10	1	14	13	31	34.5	-2.2	1.094	0.4	0.3	0	52	52	0	147	148	0	26	27
2025	10	1	14	23	31	33.3	-1.9	1.094	0.5	0.5	0	52.5	52.5	0	148	149	0	26	27
2025	10	1	14	33	31	34.7	-1.3	1.094	0.4	0.3	0	52.5	52.5	0	147	148	0	25	26
2025	10	1	14	43	31	33.7	-0.9	1.094	0.4	0.3	0	52.5	52	0	148	148	0	26	27
2025	10	1	14	53	31	33.5	-1.9	1.094	0.3	0.2	0	52.5	52	0	148	148	0	26	27
2025	10	1	15	3	31	34	-1.7	1.094	0.5	0.4	0	52	52	0	147	148	0	26	27
2025	10	1	15	13	31	34.5	-0.8	1.094	0.5	0.4	0	52	52	0	147	147	0	26	26
2025	10	1	15	23	31	34.1	-1.2	1.093	0.5	0.4	0	50.7	51.6	0	145	146	0	27	26
2025	10	1	15	33	31	33.7	-3.1	1.094	0.4	0.3	0	51.2	51.6	0	145	146	0	26	26
2025	10	1	15	43	31	34.2	-1.5	1.093	0.3	0.2	0	50.7	51.6	0	145	146	0	27	26
2025	10	1	15	53	31	33.4	-2.1	1.094	0.5	0.5	0	50.7	51.6	0	145	147	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	1	16	3	31	34	-2.1	1.093	0.6	0.5	0	51.6	51.6	0	146	147	0	26	27
2025	10	1	16	13	31	34.1	-1	1.093	0.5	0.4	0	51.6	51.6	0	146	146	0	26	26
2025	10	1	16	23	31	34.9	-1.8	1.093	0.5	0.4	0	51.2	51.2	0	145	146	0	26	27
2025	10	1	16	33	31	34.2	-1.3	1.093	0.4	0.3	0	51.6	51.6	0	146	147	0	26	27
2025	10	1	16	43	31	34.4	-2.3	1.092	0.4	0.3	0	51.2	51.6	0	146	147	0	27	27
2025	10	1	16	53	31	33.5	-0.8	1.093	0.4	0.3	0	51.2	52	0	146	147	0	27	26
2025	10	1	17	3	31	33.6	-1.7	1.093	0.5	0.4	0	51.6	52	0	146	147	0	26	26
2025	10	1	17	13	31	34.4	-1	1.093	0.3	0.2	0	51.6	51.6	0	146	147	0	26	27
2025	10	1	17	23	31	34.3	-1.7	1.092	0.4	0.3	0	51.6	51.6	0	147	147	0	27	27
2025	10	1	17	33	31	35.2	-1.2	1.093	0.4	0.3	0	52	52.5	0	147	148	0	26	26
2025	10	1	17	43	31	33.8	-1.4	1.092	0.4	0.3	0	51.2	51.6	0	145	146	0	26	26
2025	10	1	17	53	31	33.7	-0.6	1.093	0.4	0.3	0	51.6	51.6	0	146	147	0	26	27
2025	10	1	18	3	31	34.3	-0.8	1.093	0.5	0.4	0	51.2	51.6	0	146	146	0	27	26
2025	10	1	18	13	31	34.2	-2.1	1.094	0.4	0.3	0	51.2	51.6	0	146	147	0	27	27
2025	10	1	18	23	31	32.4	-1.6	1.094	0.5	0.5	0	51.6	51.2	0	147	146	0	27	27
2025	10	1	18	33	31	33.6	-1.3	1.094	0.4	0.3	0	52	52	0	147	147	0	26	26
2025	10	1	18	43	31	33.9	-2.2	1.094	0.5	0.4	0	51.6	51.6	0	146	146	0	26	26
2025	10	1	18	53	31	35.1	-1.4	1.094	0.3	0.2	0	51.6	51.6	0	147	147	0	27	27
2025	10	1	19	3	31	33.5	-1.6	1.094	0.4	0.3	0	52	52	0	147	147	0	26	26
2025	10	1	19	13	31	33.5	-2.1	1.094	0.4	0.3	0	52	52	0	147	148	0	26	27
2025	10	1	19	23	31	34.3	-1.9	1.094	0.4	0.3	0	52	52.5	0	148	148	0	27	26
2025	10	1	19	33	31	34.9	-1.9	1.094	0.5	0.4	0	52	52	0	147	147	0	26	26
2025	10	1	19	43	31	34.9	-2	1.093	0.4	0.3	0	52	52.5	0	148	148	0	27	26
2025	10	1	19	53	31	33.6	-2	1.093	0.3	0.2	0	52.5	52.5	0	148	148	0	26	26
2025	10	1	20	3	31	33.6	-0.5	1.093	0.5	0.5	0	52.5	52	0	148	148	0	26	27
2025	10	1	20	13	31	34.5	-1.6	1.093	0.3	0.2	0	52.9	52.9	0	149	149	0	26	26
2025	10	1	20	23	31	32.5	-1.1	1.093	0.5	0.4	0	52.5	52.5	0	148	149	0	26	27
2025	10	1	20	33	31	33.6	-1.7	1.093	0.5	0.4	0	52.9	52.9	0	149	149	0	26	26
2025	10	1	20	43	31	34.1	-1.9	1.093	0.4	0.3	0	52.9	52.5	0	149	149	0	26	27
2025	10	1	20	53	31	34.7	-0.4	1.093	0.4	0.3	0	52.9	52.9	0	149	149	0	26	26
2025	10	1	21	3	31	33.9	-1.5	1.093	0.4	0.3	0	53.3	52.9	0	150	150	0	26	27
2025	10	1	21	13	31	32.7	-0.8	1.092	0.3	0.2	0	52.5	53.3	0	149	150	0	27	26
2025	10	1	21	23	31	34.4	-0.9	1.092	0.3	0.2	0	52.5	53.3	0	149	150	0	27	26
2025	10	1	21	33	31	33.5	-1.3	1.092	0.4	0.3	0	52.9	53.3	0	150	150	0	27	26
2025	10	1	21	43	31	34.1	-1.9	1.092	0.5	0.4	0	52.9	52.9	0	149	150	0	26	27
2025	10	1	21	53	31	33.9	-1.1	1.092	0.3	0.2	0	52.9	52.9	0	149	150	0	26	27
2025	10	1	22	3	31	33.6	-1.7	1.092	0.4	0.3	0	52.9	53.3	0	149	150	0	26	26
2025	10	1	22	13	31	33.5	-0.6	1.091	0.4	0.3	0	53.3	53.3	0	150	150	0	26	26
2025	10	1	22	23	31	33.7	-1.5	1.091	0.4	0.3	0	53.3	53.3	0	150	150	0	26	26
2025	10	1	22	33	31	33.9	-0.4	1.091	0.5	0.4	0	52.9	53.3	0	150	150	0	27	26
2025	10	1	22	43	31	33.9	-1.3	1.09	0.5	0.4	0	53.3	53.3	0	150	151	0	26	27
2025	10	1	22	53	31	33.8	-0.5	1.089	0.3	0.2	0	53.8	53.3	0	151	151	0	26	27
2025	10	1	23	3	31	34.6	-1.1	1.089	0.4	0.3	0	53.3	53.3	0	150	151	0	26	27
2025	10	1	23	13	31	33.9	-0.6	1.089	0.4	0.3	0	53.3	53.3	0	150	150	0	26	26
2025	10	1	23	23	31	33.6	-0.6	1.089	0.5	0.4	0	53.3	53.3	0	150	151	0	26	27
2025	10	1	23	33	31	33.9	-1.7	1.088	0.3	0.2	0	52.9	53.8	0	150	151	0	27	26
2025	10	1	23	43	31	33.7	-1	1.088	0.4	0.3	0	53.3	53.3	0	150	151	0	26	27
2025	10	1	23	53	31	34.3	-2.6	1.087	0.5	0.4	0	53.8	53.3	0	151	151	0	26	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	2	0	3	31	33.7	-1.8	1.087	0.5	0.4	0	52.9	53.8	0	150	151	0	27	26
2025	10	2	0	13	31	34.2	-0.9	1.087	0.5	0.4	0	53.8	53.3	0	151	151	0	26	27
2025	10	2	0	23	31	33.4	-1.3	1.087	0.5	0.4	0	53.3	53.3	0	150	151	0	26	27
2025	10	2	0	33	31	34	-1	1.086	0.4	0.3	0	53.3	53.3	0	150	151	0	26	27
2025	10	2	0	43	31	33.7	-1.7	1.086	0.4	0.3	0	54.2	53.8	0	151	151	0	25	26
2025	10	2	0	53	31	34.7	-1.9	1.086	0.5	0.4	0	53.3	53.3	0	150	150	0	26	26
2025	10	2	1	3	31	33	-0.9	1.086	0.4	0.3	0	53.3	53.3	0	150	151	0	26	27
2025	10	2	1	13	31	33.5	-0.9	1.086	0.4	0.3	0	53.3	53.3	0	150	151	0	26	27
2025	10	2	1	23	31	34.1	-1.1	1.086	0.5	0.4	0	53.8	53.8	0	151	152	0	26	27
2025	10	2	1	33	31	34.4	-0.4	1.086	0.4	0.3	0	53.8	53.3	0	151	151	0	26	27
2025	10	2	1	43	31	33.5	-1	1.086	0.4	0.3	0	53.3	53.3	0	150	151	0	26	27
2025	10	2	1	53	31	34.4	-1.6	1.085	0.5	0.4	0	53.8	53.8	0	151	152	0	26	27
2025	10	2	2	3	31	33.5	-1	1.085	0.5	0.4	0	53.3	53.8	0	151	152	0	27	27
2025	10	2	2	13	31	33.7	-1.2	1.085	0.5	0.4	0	52.9	53.3	0	150	151	0	27	27
2025	10	2	2	23	31	33.1	-1.7	1.085	0.4	0.3	0	53.3	53.8	0	151	152	0	27	27
2025	10	2	2	33	31	33.6	-1.2	1.085	0.5	0.4	0	53.8	54.2	0	151	152	0	26	26
2025	10	2	2	43	31	34.1	-1.1	1.085	0.5	0.4	0	53.8	53.3	0	151	151	0	26	27
2025	10	2	2	53	31	34.5	-1.5	1.084	0.3	0.2	0	52.9	53.3	0	150	151	0	27	27
2025	10	2	3	3	31	34.3	-1	1.084	0.4	0.3	0	53.3	54.2	0	151	152	0	27	26
2025	10	2	3	13	31	33.1	-1.4	1.084	0.5	0.4	0	53.3	53.8	0	150	152	0	26	27
2025	10	2	3	23	31	34.1	-1.7	1.084	0.5	0.5	0	53.3	53.8	0	151	152	0	27	27
2025	10	2	3	33	31	34.7	-1.4	1.084	0.5	0.4	0	53.3	53.8	0	151	152	0	27	27
2025	10	2	3	43	31	34.1	-1.3	1.084	0.3	0.2	0	52.9	53.8	0	150	152	0	27	27
2025	10	2	3	53	31	33.5	-0.7	1.084	0.5	0.4	0	53.8	53.8	0	151	152	0	26	27
2025	10	2	4	3	31	33.1	-1.3	1.084	0.3	0.2	0	53.8	54.6	0	152	153	0	27	26
2025	10	2	4	13	31	34.4	-1.1	1.083	0.4	0.3	0	53.3	53.8	0	150	152	0	26	27
2025	10	2	4	23	31	34.1	-1.7	1.083	0.3	0.2	0	52.9	53.8	0	150	152	0	27	27
2025	10	2	4	33	31	33.6	-2	1.083	0.6	0.5	0	53.8	54.2	0	151	152	0	26	26
2025	10	2	4	43	31	34.3	-1.2	1.083	0.4	0.3	0	53.3	53.8	0	150	152	0	26	27
2025	10	2	4	53	31	33.6	-1.8	1.083	0.4	0.3	0	53.8	53.8	0	151	152	0	26	27
2025	10	2	5	3	31	34.3	-1.1	1.083	0.3	0.2	0	53.8	54.2	0	151	152	0	26	26
2025	10	2	5	13	31	34.9	-1.8	1.083	0.3	0.2	0	53.8	53.8	0	151	152	0	26	27
2025	10	2	5	23	31	33.4	-1.6	1.083	0.3	0.2	0	53.3	53.8	0	151	152	0	27	27
2025	10	2	5	33	31	33.7	-1.1	1.082	0.4	0.3	0	53.3	54.2	0	151	153	0	27	27
2025	10	2	5	43	31	33.9	-0.4	1.082	0.5	0.4	0	53.3	53.8	0	151	152	0	27	27
2025	10	2	5	53	31	34.4	-1.4	1.082	0.3	0.2	0	53.8	54.6	0	151	153	0	26	26
2025	10	2	6	3	31	34.2	-0.8	1.082	0.4	0.3	0	53.3	54.6	0	151	153	0	27	26
2025	10	2	6	13	31	33.5	-0.6	1.082	0.4	0.3	0	53.3	54.2	0	151	153	0	27	27
2025	10	2	6	23	31	33.3	-0.9	1.082	0.5	0.4	0	53.3	54.6	0	151	153	0	27	26
2025	10	2	6	33	31	33.3	-2.1	1.082	0.4	0.3	0	53.8	54.2	0	151	153	0	26	27
2025	10	2	6	43	31	33.7	-1.1	1.082	0.4	0.3	0	53.3	54.2	0	151	153	0	27	27
2025	10	2	6	53	31	33.8	-0.6	1.082	0.4	0.3	0	53.3	54.2	0	151	153	0	27	27
2025	10	2	7	3	31	33.1	-1.2	1.082	0.4	0.3	0	53.3	54.2	0	151	153	0	27	27
2025	10	2	7	13	31	33.7	-0.6	1.081	0.5	0.4	0	52.9	54.2	0	150	153	0	27	27
2025	10	2	7	23	31	33.6	-0.5	1.082	0.4	0.3	0	52.9	53.8	0	150	152	0	27	27
2025	10	2	7	33	31	34	-1.6	1.081	0.4	0.3	0	53.3	53.8	0	150	152	0	26	27
2025	10	2	7	43	31	33.8	-1.7	1.081	0.4	0.3	0	52.9	54.2	0	150	152	0	27	26
2025	10	2	7	53	31	33.2	-2.2	1.081	0.5	0.4	0	52.9	53.8	0	149	151	0	26	26

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	2	8	3	31	33.5	-1.1	1.081	0.3	0.2	0	53.3	53.8	0	150	152	0	26	27
2025	10	2	8	13	31	34.9	-2.1	1.081	0.4	0.3	0	52.5	53.3	0	149	151	0	27	27
2025	10	2	8	23	31	34.9	-1.5	1.081	0.3	0.2	0	52.9	53.3	0	149	151	0	26	27
2025	10	2	8	33	31	33.5	-1.1	1.081	0.5	0.4	0	52.9	53.3	0	149	151	0	26	27
2025	10	2	8	43	31	33.6	-0.8	1.081	0.5	0.5	0	52.9	53.3	0	149	151	0	26	27
2025	10	2	8	53	31	32.7	-1.3	1.081	0.3	0.2	0	52	53.3	0	148	151	0	27	27
2025	10	2	9	3	31	33.2	-1.1	1.08	0.4	0.3	0	52.5	52.9	0	148	150	0	26	27
2025	10	2	9	13	31	32.5	-0.7	1.081	0.3	0.2	0	52	52.9	0	148	150	0	27	27
2025	10	2	9	23	31	32.3	-1.8	1.081	0.4	0.3	0	52	52.5	0	147	149	0	26	27
2025	10	2	9	33	31	33.3	-0.9	1.08	0.4	0.3	0	52	52.5	0	147	149	0	26	27
2025	10	2	9	43	31	33.8	-1.5	1.081	0.3	0.2	0	51.6	52.5	0	147	149	0	27	27
2025	10	2	9	53	31	32.8	-2	1.081	0.3	0.2	0	51.2	52.5	0	146	149	0	27	27
2025	10	2	10	3	31	34	-2.1	1.081	0.5	0.4	0	51.6	52.5	0	146	148	0	26	26
2025	10	2	10	13	31	33.4	-1.7	1.08	0.4	0.3	0	51.6	52	0	146	148	0	26	27
2025	10	2	10	23	31	33.5	-1.9	1.08	0.5	0.4	0	50.7	52	0	145	148	0	27	27
2025	10	2	10	33	31	33.4	-2.5	1.08	0.4	0.3	0	50.7	51.6	0	145	147	0	27	27
2025	10	2	10	43	31	32.3	-1.3	1.08	0.5	0.5	0	50.7	52	0	145	148	0	27	27
2025	10	2	10	53	31	33	-1.9	1.08	0.5	0.4	0	52	52.9	0	147	149	0	26	26
2025	10	2	11	3	31	33.2	-2.6	1.08	0.5	0.4	0	51.2	52.5	0	146	149	0	27	27
2025	10	2	11	13	31	33.1	-1.9	1.08	0.5	0.4	0	51.6	52	0	146	148	0	26	27
2025	10	2	11	23	31	32.8	-2.1	1.079	0.5	0.5	0	50.3	51.6	0	144	147	0	27	27
2025	10	2	11	33	31	34.2	-0.9	1.078	0.5	0.4	0	50.3	51.2	0	143	146	0	26	27
2025	10	2	11	43	31	32.7	-1.6	1.079	0.4	0.3	0	49.9	51.6	0	143	147	0	27	27
2025	10	2	11	53	31	33.2	-2.2	1.079	0.4	0.3	0	50.3	51.2	0	143	146	0	26	27
2025	10	2	12	3	31	32.5	-2	1.078	0.4	0.3	0	50.7	51.6	0	144	147	0	26	27
2025	10	2	12	13	31	33.2	-1.3	1.078	0.4	0.3	0	50.7	52	0	144	147	0	26	26
2025	10	2	12	23	31	32.6	-0.8	1.077	0.5	0.4	0	50.3	51.2	0	143	146	0	26	27
2025	10	2	12	33	31	33.4	-0.8	1.077	0.4	0.3	0	49.9	51.2	0	143	146	0	27	27
2025	10	2	12	43	31	32.5	-1.5	1.078	0.5	0.5	0	50.3	51.2	0	143	146	0	26	27
2025	10	2	12	53	31	34.1	-1.3	1.077	0.5	0.4	0	49.9	51.2	0	142	146	0	26	27
2025	10	2	13	3	31	32.5	-1	1.077	0.4	0.3	0	49.9	51.6	0	143	146	0	27	26
2025	10	2	13	13	31	33.6	-2.1	1.077	0.4	0.3	0	49.9	51.2	0	142	146	0	26	27
2025	10	2	13	23	31	32	-1.7	1.076	0.3	0.2	0	49.9	51.6	0	143	146	0	27	26
2025	10	2	13	33	31	33.7	-1.3	1.076	0.5	0.4	0	49.5	51.2	0	142	146	0	27	27
2025	10	2	13	43	31	33	-1	1.076	0.4	0.3	0	49.9	51.2	0	142	146	0	26	27
2025	10	2	13	53	31	33.4	-2	1.075	0.5	0.4	0	49.9	51.6	0	142	146	0	26	26
2025	10	2	14	3	31	33.5	-0.8	1.076	0.4	0.3	0	49.9	51.2	0	142	146	0	26	27
2025	10	2	14	13	31	33.2	-1	1.076	0.5	0.5	0	49.9	51.2	0	142	146	0	26	27
2025	10	2	14	23	31	33.4	-1.3	1.077	0.5	0.4	0	49.5	51.2	0	142	146	0	27	27
2025	10	2	14	33	31	33.1	-2.3	1.076	0.3	0.2	0	49.5	51.2	0	142	146	0	27	27
2025	10	2	14	43	31	33.9	-1.5	1.076	0.4	0.3	0	49.9	51.2	0	142	146	0	26	27
2025	10	2	14	53	31	33.1	-1.2	1.076	0.3	0.2	0	49.5	51.6	0	142	146	0	27	26
2025	10	2	15	3	31	34	-1.3	1.076	0.5	0.5	0	49.9	51.2	0	142	146	0	26	27
2025	10	2	15	13	31	32.4	-2.2	1.075	0.4	0.3	0	50.3	51.6	0	143	147	0	26	27
2025	10	2	15	23	31	33.2	-1.5	1.076	0.3	0.2	0	49.5	51.6	0	142	146	0	27	26
2025	10	2	15	33	31	33.8	-1.9	1.076	0.4	0.3	0	49.5	52	0	142	147	0	27	26
2025	10	2	15	43	31	32.8	-1.4	1.075	0.5	0.4	0	49.9	52	0	142	147	0	26	26
2025	10	2	15	53	31	32.8	-1.2	1.075	0.4	0.3	0	50.3	52	0	143	148	0	26	27

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	2	16	3	31	32.8	-1.3	1.074	0.4	0.3	0	50.7	52	0	144	148	0	26	27
2025	10	2	16	13	31	33.9	-2.6	1.075	0.4	0.3	0	50.3	52	0	144	148	0	27	27
2025	10	2	16	23	31	34.6	-1.3	1.074	0.4	0.3	0	51.2	52.5	0	145	149	0	26	27
2025	10	2	16	33	31	33.4	-0.5	1.074	0.4	0.3	0	51.2	52.5	0	145	149	0	26	27
2025	10	2	16	43	31	34.1	-0.8	1.074	0.4	0.3	0	51.2	52.9	0	145	149	0	26	26
2025	10	2	16	53	31	33.7	-0.9	1.075	0.4	0.3	0	50.3	52	0	143	148	0	26	27
2025	10	2	17	3	31	33.3	-1.8	1.075	0.3	0.2	0	50.3	52	0	143	147	0	26	26
2025	10	2	17	13	31	33.3	-1.3	1.074	0.5	0.4	0	51.2	52.9	0	145	150	0	26	27
2025	10	2	17	23	31	33.2	-1.3	1.074	0.4	0.3	0	51.2	52.9	0	145	149	0	26	26
2025	10	2	17	33	31	34.6	-1.7	1.073	0.5	0.4	0	51.6	52.9	0	146	149	0	26	26
2025	10	2	17	43	31	32.7	-1.6	1.074	0.4	0.3	0	51.2	52.9	0	145	149	0	26	26
2025	10	2	17	53	31	33.5	-1.1	1.074	0.3	0.2	0	51.6	52.5	0	146	149	0	26	27
2025	10	2	18	3	31	33.5	-1.4	1.073	0.4	0.3	0	51.6	52.5	0	146	149	0	26	27
2025	10	2	18	13	31	33	-1.9	1.074	0.4	0.3	0	51.6	52.5	0	146	149	0	26	27
2025	10	2	18	23	31	32.8	-0.7	1.074	0.5	0.4	0	51.2	52.9	0	145	150	0	26	27
2025	10	2	18	33	31	33.1	-2	1.073	0.3	0.2	0	51.6	52.5	0	146	149	0	26	27
2025	10	2	18	43	31	32.6	-0.9	1.073	0.5	0.4	0	51.6	52.9	0	146	150	0	26	27
2025	10	2	18	53	31	33.1	-1.5	1.073	0.5	0.4	0	51.2	53.3	0	146	150	0	27	26
2025	10	2	19	3	31	33.3	-2.2	1.074	0.4	0.3	0	51.6	53.3	0	146	150	0	26	26
2025	10	2	19	13	31	33.7	-1.2	1.073	0.5	0.4	0	52	53.8	0	147	151	0	26	26
2025	10	2	19	23	31	32.3	-1.2	1.073	0.5	0.4	0	51.6	53.3	0	147	151	0	27	27
2025	10	2	19	33	31	33.1	-1.5	1.073	0.5	0.4	0	52	53.8	0	148	151	0	27	26
2025	10	2	19	43	31	34.6	-0.8	1.073	0.5	0.4	0	52.5	53.8	0	148	151	0	26	26
2025	10	2	19	53	31	33.1	-1.3	1.073	0.4	0.3	0	52.5	53.8	0	148	152	0	26	27
2025	10	2	20	3	31	34	-1.8	1.073	0.4	0.3	0	52	53.3	0	148	151	0	27	27
2025	10	2	20	13	31	33.5	-1.9	1.073	0.5	0.4	0	52.9	54.2	0	149	152	0	26	26
2025	10	2	20	23	31	32.4	-1	1.073	0.5	0.4	0	52	54.2	0	148	152	0	27	26
2025	10	2	20	33	31	32.8	-1.1	1.073	0.5	0.4	0	52.5	53.8	0	148	152	0	26	27
2025	10	2	20	43	31	33.1	-0.6	1.072	0.5	0.4	0	52.9	53.8	0	149	152	0	26	27
2025	10	2	20	53	31	32.3	-0.9	1.073	0.4	0.3	0	52.9	53.8	0	149	152	0	26	27
2025	10	2	21	3	31	32.6	-1.3	1.073	0.5	0.4	0	52.9	54.2	0	149	152	0	26	26
2025	10	2	21	13	31	33.8	-1.7	1.072	0.5	0.4	0	52.5	53.8	0	149	152	0	27	27
2025	10	2	21	23	31	33	-1.1	1.072	0.5	0.4	0	52.9	54.2	0	149	152	0	26	26
2025	10	2	21	33	31	34.1	-0.6	1.073	0.5	0.4	0	52.5	53.8	0	148	152	0	26	27
2025	10	2	21	43	31	33	-0.8	1.072	0.5	0.4	0	52.9	53.8	0	149	152	0	26	27
2025	10	2	21	53	31	33.6	-0.9	1.072	0.5	0.4	0	53.3	54.2	0	149	153	0	25	27
2025	10	2	22	3	31	32.9	-0.7	1.072	0.5	0.4	0	52.9	54.6	0	149	153	0	26	26
2025	10	2	22	13	31	33.2	-2.2	1.073	0.4	0.3	0	52.5	54.2	0	149	153	0	27	27
2025	10	2	22	23	31	32.5	-1.3	1.073	0.5	0.4	0	52.9	52.5	0	149	148	0	26	26
2025	10	2	22	33	31	33.6	-1.9	1.072	0.4	0.3	0	52.9	52.5	0	149	148	0	26	26
2025	10	2	22	43	31	33.8	-1.6	1.072	0.5	0.4	0	52.9	52.5	0	149	149	0	26	27
2025	10	2	22	53	31	32.5	-0.7	1.072	0.5	0.4	0	52.5	54.2	0	149	153	0	27	27
2025	10	2	23	3	31	33.5	-1.5	1.072	0.4	0.3	0	52.9	54.2	0	149	153	0	26	27
2025	10	2	23	13	31	32.6	-1.7	1.072	0.4	0.3	0	52.9	54.2	0	149	153	0	26	27
2025	10	2	23	23	31	33.7	-0.2	1.072	0.3	0.2	0	52.5	54.2	0	149	153	0	27	27
2025	10	2	23	33	31	32.4	-1	1.072	0.4	0.3	0	52.5	54.2	0	149	153	0	27	27
2025	10	2	23	43	31	34.2	-1.2	1.072	0.3	0.2	0	52.9	54.6	0	150	154	0	27	27
2025	10	2	23	53	31	33	-1.9	1.072	0.5	0.5	0	52.9	54.6	0	150	153	0	27	26

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	3	0	3	31	32	-2.4	1.072	0.4	0.3	0	52.5	54.6	0	149	154	0	27	27
2025	10	3	0	13	31	33	-1.3	1.072	0.5	0.4	0	52.9	54.6	0	149	153	0	26	26
2025	10	3	0	23	31	32.3	-1.3	1.072	0.5	0.4	0	52.5	55	0	149	154	0	27	26
2025	10	3	0	33	31	34	-1.7	1.072	0.5	0.4	0	52.5	54.2	0	149	153	0	27	27
2025	10	3	0	43	31	33.6	-2.2	1.072	0.3	0.2	0	53.3	54.6	0	150	154	0	26	27
2025	10	3	0	53	31	33.2	-1.5	1.072	0.4	0.3	0	52.5	54.6	0	149	154	0	27	27
2025	10	3	1	3	31	32.9	-1.8	1.072	0.5	0.4	0	52.5	54.2	0	149	153	0	27	27
2025	10	3	1	13	31	32.9	-1.5	1.072	0.4	0.3	0	53.3	54.2	0	150	153	0	26	27
2025	10	3	1	23	31	33.3	-1.6	1.072	0.5	0.4	0	53.3	54.6	0	150	154	0	26	27
2025	10	3	1	33	31	34	-1.8	1.072	0.5	0.4	0	52.9	54.2	0	149	153	0	26	27
2025	10	3	1	43	31	32.9	-0.7	1.072	0.4	0.3	0	52.9	55	0	149	154	0	26	26
2025	10	3	1	53	31	33.5	-1.7	1.072	0.4	0.3	0	52.9	54.2	0	149	153	0	26	27
2025	10	3	2	3	31	34.2	-1.3	1.072	0.3	0.2	0	52.5	54.6	0	149	154	0	27	27
2025	10	3	2	13	31	34.2	-1.5	1.073	0.4	0.3	0	52.5	54.6	0	149	154	0	27	27
2025	10	3	2	23	31	33	-1.2	1.072	0.4	0.3	0	52.9	54.6	0	149	154	0	26	27
2025	10	3	2	33	31	33.1	-1.6	1.073	0.4	0.3	0	52.9	54.6	0	149	154	0	26	27
2025	10	3	2	43	31	33.8	-1.2	1.073	0.4	0.3	0	53.3	54.6	0	150	154	0	26	27
2025	10	3	2	53	31	34	-1.7	1.072	0.5	0.4	0	52.9	55	0	150	154	0	27	26
2025	10	3	3	3	31	33.4	-0.8	1.073	0.5	0.4	0	52.9	54.6	0	149	154	0	26	27
2025	10	3	3	13	31	33.3	-1.7	1.073	0.5	0.4	0	52.5	54.6	0	149	153	0	27	26
2025	10	3	3	23	31	33.2	-1.5	1.073	0.4	0.3	0	52.5	54.6	0	149	154	0	27	27
2025	10	3	3	33	31	32.9	-1.7	1.073	0.5	0.5	0	52.9	54.6	0	149	154	0	26	27
2025	10	3	3	43	31	32.9	-0.9	1.073	0.3	0.2	0	54.2	55	0	153	154	0	27	26
2025	10	3	3	53	31	33	-1.5	1.073	0.4	0.3	0	54.2	55	0	153	154	0	27	26
2025	10	3	4	3	31	33.3	-1.1	1.073	0.5	0.4	0	55	55	0	154	154	0	26	26
2025	10	3	4	13	31	32.1	-0.9	1.073	0.5	0.4	0	54.6	55.5	0	154	155	0	27	26
2025	10	3	4	23	31	33.3	-1.9	1.073	0.5	0.4	0	54.6	55	0	153	154	0	26	26
2025	10	3	4	33	31	34.2	-2.1	1.073	0.3	0.2	0	54.2	55	0	153	155	0	27	27
2025	10	3	4	43	31	34.3	-2.5	1.073	0.4	0.3	0	54.6	55.5	0	154	155	0	27	26
2025	10	3	4	53	31	33.5	-1.3	1.073	0.4	0.3	0	54.6	55.5	0	154	155	0	27	26
2025	10	3	5	3	31	33.3	-1.7	1.073	0.4	0.3	0	55	55	0	154	155	0	26	27
2025	10	3	5	13	31	33.9	-0.4	1.074	0.3	0.2	0	55	55.5	0	154	155	0	26	26
2025	10	3	5	23	31	33.6	-2.1	1.073	0.4	0.3	0	54.6	55	0	154	155	0	27	27
2025	10	3	5	33	31	33.2	-1.7	1.074	0.5	0.5	0	55	55	0	154	155	0	26	27
2025	10	3	5	43	31	33.3	-2.1	1.074	0.4	0.3	0	54.6	55.5	0	154	155	0	27	26
2025	10	3	5	53	31	33	-0.7	1.074	0.5	0.5	0	55	55.5	0	154	155	0	26	26
2025	10	3	6	3	31	33.6	-0.6	1.074	0.6	0.5	0	54.2	55	0	153	155	0	27	27
2025	10	3	6	13	31	33.2	-0.7	1.074	0.4	0.3	0	55	55.5	0	154	155	0	26	26
2025	10	3	6	23	31	33.9	0.3	1.074	0.4	0.3	0	55	55	0	154	155	0	26	27
2025	10	3	6	33	31	32.4	-0.3	1.074	0.4	0.3	0	55	55.5	0	154	155	0	26	26
2025	10	3	6	43	31	32.8	-1	1.074	0.3	0.2	0	55	55.9	0	154	156	0	26	26
2025	10	3	6	53	31	33.7	-1.5	1.074	0.3	0.2	0	55	55.9	0	155	157	0	27	27
2025	10	3	7	3	31	34.3	-1.5	1.074	0.5	0.4	0	54.6	55.9	0	154	156	0	27	26
2025	10	3	7	13	31	32.7	-0.5	1.074	0.4	0.3	0	55	55	0	154	155	0	26	27
2025	10	3	7	23	31	32.9	-1.9	1.074	0.5	0.5	0	54.6	55	0	153	155	0	26	27
2025	10	3	7	33	31	31.8	-1.1	1.074	0.4	0.3	0	54.6	55.5	0	153	155	0	26	26
2025	10	3	7	43	31	33.2	-1.7	1.075	0.4	0.3	0	54.6	55.5	0	153	155	0	26	26
2025	10	3	7	53	31	34.2	0	1.075	0.5	0.5	0	54.2	55	0	153	155	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	3	8	3	31	32	-0.7	1.075	0.4	0.3	0	54.2	55	0	153	155	0	27	27
2025	10	3	8	13	31	33.7	-2.1	1.075	0.4	0.3	0	53.8	55	0	152	154	0	27	26
2025	10	3	8	23	31	34.5	-1.6	1.075	0.4	0.3	0	54.2	54.6	0	152	154	0	26	27
2025	10	3	8	33	31	33.1	-1.6	1.076	0.5	0.5	0	53.8	54.6	0	152	154	0	27	27
2025	10	3	8	43	31	33.6	-0.7	1.076	0.4	0.3	0	53.8	55	0	152	154	0	27	26
2025	10	3	8	53	31	34.1	-1.3	1.077	0.3	0.2	0	53.3	54.6	0	151	153	0	27	26
2025	10	3	9	3	31	33.2	-1.3	1.076	0.4	0.3	0	53.3	54.2	0	151	153	0	27	27
2025	10	3	9	13	31	33.2	-1.7	1.077	0.4	0.3	0	53.8	54.2	0	151	153	0	26	27
2025	10	3	9	23	31	33.3	-1.7	1.076	0.4	0.3	0	53.3	53.8	0	150	152	0	26	27
2025	10	3	9	33	31	33	-0.5	1.077	0.3	0.2	0	53.3	54.2	0	151	153	0	27	27
2025	10	3	9	43	31	33.7	-1.7	1.076	0.4	0.3	0	54.2	55	0	152	154	0	26	26
2025	10	3	9	53	31	32.7	-1.3	1.076	0.5	0.4	0	54.2	54.6	0	152	154	0	26	27
2025	10	3	10	3	31	33.6	-1.8	1.076	0.4	0.3	0	53.8	54.6	0	152	154	0	27	27
2025	10	3	10	13	31	33.5	-0.5	1.076	0.4	0.3	0	53.3	54.2	0	151	153	0	27	27
2025	10	3	10	23	31	33.3	-1.4	1.076	0.3	0.2	0	52.5	53.8	0	149	151	0	27	26
2025	10	3	10	33	31	34	-1.5	1.076	0.5	0.5	0	52.5	53.3	0	149	151	0	27	27
2025	10	3	10	43	31	32.4	-2.2	1.077	0.4	0.3	0	52.9	53.3	0	149	151	0	26	27
2025	10	3	10	53	31	33.7	-1.3	1.076	0.3	0.2	0	52.9	53.3	0	149	151	0	26	27
2025	10	3	11	3	31	33.2	-1.2	1.076	0.4	0.3	0	52.9	53.3	0	149	151	0	26	27
2025	10	3	11	13	31	32.8	-1.4	1.076	0.4	0.3	0	52.5	53.3	0	149	151	0	27	27
2025	10	3	11	23	31	33.8	-1.6	1.076	0.4	0.3	0	52.5	53.3	0	148	150	0	26	26
2025	10	3	11	33	31	33.3	-1	1.077	0.5	0.4	0	52.5	52.9	0	148	150	0	26	27
2025	10	3	11	43	31	33.3	-1.3	1.076	0.4	0.3	0	52	53.3	0	148	150	0	27	26
2025	10	3	11	53	31	33.7	-1.5	1.076	0.3	0.2	0	52.5	52.9	0	148	150	0	26	27
2025	10	3	12	3	31	34	-1.7	1.076	0.5	0.4	0	52	52.9	0	147	150	0	26	27
2025	10	3	12	13	31	33.6	-0.6	1.076	0.4	0.3	0	52	53.3	0	147	150	0	26	26
2025	10	3	12	23	31	32.8	-0.1	1.076	0.4	0.3	0	51.6	52.5	0	146	149	0	26	27
2025	10	3	12	33	31	33.2	-1	1.076	0.5	0.5	0	51.6	52.5	0	146	149	0	26	27
2025	10	3	12	43	31	32.6	-0.9	1.076	0.5	0.4	0	52	52.9	0	147	149	0	26	26
2025	10	3	12	53	31	32.1	-0.6	1.076	0.4	0.3	0	52	52.9	0	147	150	0	26	27
2025	10	3	13	3	31	33.1	-2.4	1.076	0.4	0.3	0	51.2	52.5	0	146	149	0	27	27
2025	10	3	13	13	31	32.2	-0.4	1.076	0.5	0.4	0	51.6	53.3	0	147	150	0	27	26
2025	10	3	13	23	31	33.2	-1.3	1.076	0.5	0.4	0	51.6	53.3	0	147	150	0	27	26
2025	10	3	13	33	31	33.6	-1.3	1.076	0.5	0.4	0	52	52.9	0	147	150	0	26	27
2025	10	3	13	43	31	33.9	-1.8	1.076	0.3	0.2	0	52	53.3	0	148	151	0	27	27
2025	10	3	13	53	31	31.8	-1.3	1.076	0.4	0.3	0	51.6	52.9	0	146	149	0	26	26
2025	10	3	14	3	31	33.1	-1.4	1.077	0.4	0.3	0	51.2	52.9	0	146	149	0	27	26
2025	10	3	14	13	31	32.6	-2.4	1.077	0.3	0.2	0	51.6	52.5	0	146	149	0	26	27
2025	10	3	14	23	31	32.5	-0.9	1.077	0.5	0.4	0	52.5	53.8	0	148	151	0	26	26
2025	10	3	14	33	31	32.9	-0.2	1.076	0.5	0.4	0	52.5	53.3	0	148	150	0	26	26
2025	10	3	14	43	31	33.1	-1.7	1.076	0.4	0.3	0	52	53.3	0	148	151	0	27	27
2025	10	3	14	53	31	33.9	-1.7	1.076	0.4	0.3	0	52	53.3	0	148	151	0	27	27
2025	10	3	15	3	31	34	-0.6	1.077	0.5	0.4	0	52.5	53.3	0	148	151	0	26	27
2025	10	3	15	13	31	33.2	-1.3	1.077	0.4	0.3	0	53.3	54.2	0	150	153	0	26	27
2025	10	3	15	23	31	32.8	-1.3	1.076	0.4	0.3	0	52.9	53.8	0	149	152	0	26	27
2025	10	3	15	33	31	33.9	-0.5	1.077	0.3	0.2	0	52.5	54.2	0	149	152	0	27	26
2025	10	3	15	43	31	33.6	-1.2	1.076	0.5	0.5	0	52	53.3	0	147	150	0	26	26
2025	10	3	15	53	31	33.2	-1	1.076	0.5	0.4	0	52	52.9	0	147	150	0	26	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	3	16	3	31	33.7	-1	1.077	0.5	0.4	0	51.6	52.9	0	146	149	0	26	26
2025	10	3	16	13	31	34.8	-1.7	1.076	0.4	0.3	0	53.3	53.8	0	150	152	0	26	27
2025	10	3	16	23	31	34.1	-1.7	1.076	0.4	0.3	0	52.9	54.2	0	149	152	0	26	26
2025	10	3	16	33	31	34.3	-1.6	1.076	0.4	0.3	0	53.3	54.6	0	150	153	0	26	26
2025	10	3	16	43	31	32.8	0	1.077	0.5	0.4	0	53.3	54.2	0	150	153	0	26	27
2025	10	3	16	53	31	34	-0.8	1.076	0.3	0.2	0	52.5	53.8	0	148	152	0	26	27
2025	10	3	17	3	31	33.5	-1.2	1.076	0.4	0.3	0	52	53.3	0	148	151	0	27	27
2025	10	3	17	13	31	33.2	-1.2	1.076	0.4	0.3	0	52.5	53.8	0	148	151	0	26	26
2025	10	3	17	23	31	33.8	-1.6	1.076	0.4	0.3	0	52.9	54.2	0	149	152	0	26	26
2025	10	3	17	33	31	33.5	-1.7	1.076	0.5	0.4	0	52.5	54.2	0	149	152	0	27	26
2025	10	3	17	43	31	33.3	-0.3	1.077	0.4	0.3	0	52	53.8	0	148	152	0	27	27
2025	10	3	17	53	31	34.4	-1.1	1.076	0.4	0.3	0	52.9	54.2	0	149	152	0	26	26
2025	10	3	18	3	31	33.8	-0.8	1.077	0.4	0.3	0	52	53.8	0	148	151	0	27	26
2025	10	3	18	13	31	33.4	-1.3	1.077	0.5	0.4	0	52.5	53.8	0	148	151	0	26	26
2025	10	3	18	23	31	33.4	-1.6	1.076	0.4	0.3	0	52.5	53.8	0	148	151	0	26	26
2025	10	3	18	33	31	33.8	-0.4	1.076	0.5	0.4	0	52	53.3	0	148	151	0	27	27
2025	10	3	18	43	31	33.7	-2	1.076	0.4	0.3	0	52.5	53.8	0	148	151	0	26	26
2025	10	3	18	53	31	33.1	-0.9	1.076	0.5	0.5	0	52.5	53.3	0	148	151	0	26	27
2025	10	3	19	3	31	32.9	-1.4	1.076	0.3	0.2	0	52.5	53.8	0	148	151	0	26	26
2025	10	3	19	13	31	33	-1.2	1.076	0.3	0.2	0	52	54.2	0	148	152	0	27	26
2025	10	3	19	23	31	33.6	0	1.077	0.4	0.3	0	52.5	54.2	0	148	152	0	26	26
2025	10	3	19	33	31	33.2	-1.3	1.077	0.3	0.2	0	52	53.8	0	148	152	0	27	27
2025	10	3	19	43	31	33.5	-0.7	1.077	0.5	0.4	0	52	54.2	0	148	152	0	27	26
2025	10	3	19	53	31	34	-1.5	1.077	0.4	0.3	0	52.5	53.8	0	148	152	0	26	27
2025	10	3	20	3	31	33.4	-1.6	1.077	0.3	0.2	0	52.5	53.8	0	149	152	0	27	27
2025	10	3	20	13	31	33.3	-0.5	1.077	0.4	0.3	0	52.9	53.8	0	149	152	0	26	27
2025	10	3	20	23	31	33.9	-1.3	1.077	0.5	0.4	0	52.9	53.8	0	149	152	0	26	27
2025	10	3	20	33	31	32.9	-0.9	1.077	0.5	0.4	0	52.9	53.8	0	149	152	0	26	27
2025	10	3	20	43	31	33.6	-2.3	1.077	0.4	0.3	0	53.3	54.2	0	150	153	0	26	27
2025	10	3	20	53	31	34.8	-1.2	1.077	0.4	0.3	0	52.5	54.2	0	149	153	0	27	27
2025	10	3	21	3	31	32.2	0	1.078	0.6	0.5	0	53.3	55	0	150	154	0	26	26
2025	10	3	21	13	31	32.9	-0.9	1.078	0.5	0.4	0	52.9	54.6	0	150	154	0	27	27
2025	10	3	21	23	31	33.1	-2	1.078	0.3	0.2	0	52.9	54.2	0	149	153	0	26	27
2025	10	3	21	33	31	34.1	-1.7	1.078	0.4	0.3	0	52.5	54.6	0	149	153	0	27	26
2025	10	3	21	43	31	33.1	-2.1	1.078	0.5	0.4	0	52.9	54.2	0	149	153	0	26	27
2025	10	3	21	53	31	32.6	-1.7	1.078	0.7	0.6	0	52.9	54.2	0	149	153	0	26	27
2025	10	3	22	3	31	33.4	-1.9	1.078	0.5	0.4	0	52.9	53.8	0	149	152	0	26	27
2025	10	3	22	13	31	34.2	-2.2	1.078	0.5	0.4	0	52.5	54.2	0	149	153	0	27	27
2025	10	3	22	23	31	32.7	-1.4	1.078	0.5	0.5	0	52.5	54.2	0	149	153	0	27	27
2025	10	3	22	33	31	33.3	-0.9	1.078	0.5	0.5	0	52.9	54.6	0	149	153	0	26	26
2025	10	3	22	43	31	32.9	-1.7	1.078	0.5	0.5	0	52.5	54.6	0	149	153	0	27	26
2025	10	3	22	53	31	33.2	-1.7	1.078	0.3	0.2	0	52.5	54.2	0	149	153	0	27	27
2025	10	3	23	3	31	33.8	-1.8	1.078	0.3	0.2	0	52.9	54.2	0	149	153	0	26	27
2025	10	3	23	13	31	33.7	-1.6	1.078	0.5	0.4	0	52.5	54.6	0	149	153	0	27	26
2025	10	3	23	23	31	33.5	-1.1	1.078	0.4	0.3	0	52.5	54.2	0	149	153	0	27	27
2025	10	3	23	33	31	32.1	-1	1.078	0.4	0.3	0	51.6	54.6	0	147	153	0	27	26
2025	10	3	23	43	31	33.8	-1.4	1.078	0.4	0.3	0	51.6	54.2	0	146	153	0	26	27
2025	10	3	23	53	31	32.9	-1.6	1.078	0.5	0.4	0	51.6	54.6	0	146	153	0	26	26

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	4	0	3	31	32.6	-1.8	1.078	0.3	0.2	0	52.5	54.2	0	148	153	0	26	27
2025	10	4	0	13	31	31.7	-1.6	1.078	0.4	0.3	0	52	54.2	0	148	153	0	27	27
2025	10	4	0	23	31	34.5	-1.2	1.079	0.5	0.5	0	52.5	54.2	0	149	153	0	27	27
2025	10	4	0	33	31	32.4	-1.8	1.078	0.5	0.4	0	52.5	54.2	0	149	153	0	27	27
2025	10	4	0	43	31	32.9	-0.2	1.078	0.5	0.4	0	52.9	54.6	0	149	154	0	26	27
2025	10	4	0	53	31	32.9	-1.2	1.078	0.3	0.2	0	52.5	54.2	0	149	153	0	27	27
2025	10	4	1	3	31	32.4	0	1.078	0.5	0.4	0	52.5	54.6	0	149	154	0	27	27
2025	10	4	1	13	31	33.5	-0.4	1.079	0.4	0.3	0	52.5	54.2	0	149	153	0	27	27
2025	10	4	1	23	31	34.3	-2.2	1.078	0.4	0.3	0	52.5	54.2	0	149	153	0	27	27
2025	10	4	1	33	31	33	-1.6	1.079	0.5	0.4	0	52.9	54.6	0	149	154	0	26	27
2025	10	4	1	43	31	33.5	-1.9	1.079	0.4	0.3	0	52.5	54.2	0	149	153	0	27	27
2025	10	4	1	53	31	33.1	-1.6	1.078	0.5	0.5	0	52.5	54.2	0	149	153	0	27	27
2025	10	4	2	3	31	33.9	-1.8	1.078	0.5	0.4	0	52.9	54.6	0	149	154	0	26	27
2025	10	4	2	13	31	33.3	-1.4	1.079	0.4	0.3	0	52.5	54.6	0	149	154	0	27	27
2025	10	4	2	23	31	33.6	-1.6	1.079	0.3	0.2	0	52.9	54.6	0	149	153	0	26	26
2025	10	4	2	33	31	33.4	-2	1.079	0.4	0.3	0	52.5	54.2	0	149	153	0	27	27
2025	10	4	2	43	31	33.4	-0.4	1.079	0.3	0.2	0	52.5	54.6	0	149	154	0	27	27
2025	10	4	2	53	31	33.6	-1.9	1.079	0.4	0.3	0	52.5	54.2	0	149	153	0	27	27
2025	10	4	3	3	31	32.9	-1	1.079	0.3	0.2	0	52.9	54.6	0	149	154	0	26	27
2025	10	4	3	13	31	32.7	-1.7	1.079	0.4	0.3	0	52.5	54.2	0	149	154	0	27	28
2025	10	4	3	23	31	32.7	-1.2	1.078	0.3	0.2	0	52.5	54.6	0	149	154	0	27	27
2025	10	4	3	33	31	33.7	-1.5	1.078	0.5	0.4	0	52.9	55	0	149	154	0	26	26
2025	10	4	3	43	31	33.7	-2	1.078	0.5	0.4	0	52.5	54.2	0	149	153	0	27	27
2025	10	4	3	53	31	32.7	-0.7	1.078	0.4	0.3	0	52.5	54.6	0	149	154	0	27	27
2025	10	4	4	3	31	33.1	-1	1.078	0.3	0.2	0	52.9	54.6	0	150	154	0	27	27
2025	10	4	4	13	31	32.5	-1.1	1.078	0.5	0.4	0	53.3	54.6	0	150	154	0	26	27
2025	10	4	4	23	31	32.7	-2.1	1.078	0.5	0.4	0	53.3	54.6	0	150	154	0	26	27
2025	10	4	4	33	31	33	-0.8	1.078	0.5	0.4	0	52.5	54.2	0	149	153	0	27	27
2025	10	4	4	43	31	34.6	-1.9	1.078	0.4	0.3	0	52.5	54.2	0	149	153	0	27	27
2025	10	4	4	53	31	33.2	-1.5	1.078	0.5	0.4	0	52.9	54.2	0	150	153	0	27	27
2025	10	4	5	3	31	32.1	-1.4	1.078	0.3	0.2	0	52.5	54.2	0	149	153	0	27	27
2025	10	4	5	13	31	33.2	-1.7	1.078	0.5	0.4	0	52.9	54.2	0	149	153	0	26	27
2025	10	4	5	23	31	33.4	-3	1.078	0.3	0.2	0	52.5	54.6	0	149	153	0	27	26
2025	10	4	5	33	31	33	-0.8	1.078	0.4	0.3	0	52.9	54.6	0	149	154	0	26	27
2025	10	4	5	43	31	33.5	-1.7	1.078	0.4	0.3	0	52.9	54.6	0	150	154	0	27	27
2025	10	4	5	53	31	32.5	-1.6	1.078	0.4	0.3	0	52.9	54.6	0	150	154	0	27	27
2025	10	4	6	3	31	33.4	-1.4	1.078	0.4	0.3	0	52.9	54.6	0	150	154	0	27	27
2025	10	4	6	13	31	33	-1.5	1.078	0.4	0.3	0	52.5	54.6	0	149	154	0	27	27
2025	10	4	6	23	31	33.1	-0.6	1.078	0.5	0.5	0	52.9	53.8	0	150	152	0	27	27
2025	10	4	6	33	31	33.8	-1.3	1.078	0.5	0.4	0	53.8	55.5	0	150	155	0	25	26
2025	10	4	6	43	31	33	-0.6	1.078	0.4	0.3	0	52.9	54.6	0	150	154	0	27	27
2025	10	4	6	53	31	33.8	-1.1	1.078	0.4	0.3	0	52.9	54.6	0	150	154	0	27	27
2025	10	4	7	3	31	33.8	-1	1.078	0.4	0.3	0	52.9	54.6	0	150	154	0	27	27
2025	10	4	7	13	31	32.7	-0.8	1.078	0.4	0.3	0	52.5	54.6	0	149	154	0	27	27
2025	10	4	7	23	31	33	-1.5	1.078	0.4	0.3	0	52.5	54.2	0	149	153	0	27	27
2025	10	4	7	33	31	34.1	-1.4	1.078	0.4	0.3	0	52.5	53.8	0	149	153	0	27	28
2025	10	4	7	43	31	33.2	-1	1.078	0.4	0.3	0	52	54.2	0	148	153	0	27	27
2025	10	4	7	53	31	32.2	-0.7	1.078	0.4	0.3	0	52	53.8	0	148	152	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	4	8	3	31	34.4	-0.9	1.078	0.4	0.3	0	52.5	53.3	0	148	152	0	26	28
2025	10	4	8	13	31	33.3	0	1.078	0.5	0.5	0	52	53.8	0	148	153	0	27	28
2025	10	4	8	23	31	33.5	-1	1.078	0.4	0.3	0	52	53.8	0	148	152	0	27	27
2025	10	4	8	33	31	34	-1.3	1.078	0.5	0.4	0	52	53.8	0	148	152	0	27	27
2025	10	4	8	43	31	32.9	-1.7	1.078	0.4	0.3	0	51.6	53.3	0	147	151	0	27	27
2025	10	4	8	53	31	33.2	-0.8	1.078	0.5	0.4	0	51.6	53.3	0	147	151	0	27	27
2025	10	4	9	3	31	32.1	-2.5	1.078	0.4	0.3	0	51.6	53.3	0	147	151	0	27	27
2025	10	4	9	13	31	33.2	-0.9	1.078	0.3	0.2	0	52	53.3	0	147	151	0	26	27
2025	10	4	9	23	31	33	-1.8	1.078	0.5	0.4	0	51.2	53.3	0	146	151	0	27	27
2025	10	4	9	33	31	32.7	-1.7	1.078	0.3	0.2	0	51.2	53.3	0	146	151	0	27	27
2025	10	4	9	43	31	32.4	-1.7	1.078	0.5	0.4	0	51.2	53.3	0	146	151	0	27	27
2025	10	4	9	53	31	33.2	-1.7	1.078	0.3	0.2	0	51.2	52.9	0	146	150	0	27	27
2025	10	4	10	3	31	32.1	-1.6	1.078	0.4	0.3	0	51.6	52.9	0	146	150	0	26	27
2025	10	4	10	13	31	33.3	-0.8	1.078	0.3	0.2	0	51.2	52.9	0	146	151	0	27	28
2025	10	4	10	23	31	34.8	-1	1.078	0.4	0.3	0	51.6	53.3	0	147	151	0	27	27
2025	10	4	10	33	31	34.5	-0.5	1.078	0.4	0.3	0	51.6	53.3	0	147	151	0	27	27
2025	10	4	10	43	31	32.9	-1.4	1.078	0.4	0.3	0	51.6	53.3	0	147	151	0	27	27
2025	10	4	10	53	31	32.9	-0.9	1.078	0.5	0.4	0	51.2	52.9	0	146	150	0	27	27
2025	10	4	11	3	31	33	-1.3	1.078	0.4	0.3	0	50.3	52	0	144	148	0	27	27
2025	10	4	11	13	31	33.2	-1.5	1.078	0.4	0.3	0	49.5	51.6	0	143	147	0	28	27
2025	10	4	11	23	31	34	-2.3	1.078	0.5	0.4	0	49.9	52	0	143	148	0	27	27
2025	10	4	11	33	31	33	-1.3	1.078	0.4	0.3	0	49.9	51.6	0	143	147	0	27	27
2025	10	4	11	43	31	33.8	-1.7	1.078	0.5	0.4	0	49.9	50.7	0	142	146	0	26	28
2025	10	4	11	53	31	33	-0.8	1.078	0.3	0.2	0	49.5	51.2	0	142	146	0	27	27
2025	10	4	12	3	31	32.7	-1.5	1.078	0.4	0.3	0	49.5	51.2	0	142	146	0	27	27
2025	10	4	12	13	31	32.8	-1.1	1.078	0.4	0.3	0	49	51.2	0	141	146	0	27	27
2025	10	4	12	23	31	32.4	-1.8	1.078	0.4	0.3	0	49	51.2	0	141	146	0	27	27
2025	10	4	12	33	31	33.9	-1.9	1.078	0.5	0.4	0	49	50.3	0	141	145	0	27	28
2025	10	4	12	43	31	33.6	-0.4	1.078	0.6	0.5	0	48.6	50.7	0	140	145	0	27	27
2025	10	4	12	53	31	32.7	-1.8	1.078	0.5	0.4	0	48.2	50.7	0	139	145	0	27	27
2025	10	4	13	3	31	32.4	-1.3	1.078	0.5	0.4	0	48.6	49.9	0	139	144	0	26	28
2025	10	4	13	13	31	33.1	-2.3	1.078	0.3	0.2	0	48.2	49.9	0	139	144	0	27	28
2025	10	4	13	23	31	32.5	-2.1	1.078	0.3	0.2	0	48.2	50.3	0	139	144	0	27	27
2025	10	4	13	33	31	32.9	-1.7	1.078	0.3	0.2	0	48.2	50.3	0	139	144	0	27	27
2025	10	4	13	43	31	33.1	-1.5	1.078	0.5	0.4	0	48.2	50.3	0	139	144	0	27	27
2025	10	4	13	53	31	33	-1.7	1.078	0.4	0.3	0	48.2	49.9	0	138	143	0	26	27
2025	10	4	14	3	31	33.1	-1.3	1.078	0.4	0.3	0	48.2	49.9	0	139	144	0	27	28
2025	10	4	14	13	31	32.9	-1.5	1.078	0.5	0.4	0	48.6	50.3	0	139	144	0	26	27
2025	10	4	14	23	31	32.7	-1.7	1.078	0.4	0.3	0	48.6	50.7	0	140	145	0	27	27
2025	10	4	14	33	31	33	-2.3	1.078	0.4	0.3	0	48.6	50.3	0	139	144	0	26	27
2025	10	4	14	43	31	33.8	-0.9	1.078	0.5	0.4	0	48.6	50.3	0	139	144	0	26	27
2025	10	4	14	53	31	33.7	-2.5	1.078	0.3	0.2	0	48.2	50.3	0	139	144	0	27	27
2025	10	4	15	3	31	33.8	-0.9	1.078	0.4	0.3	0	48.2	50.7	0	140	145	0	28	27
2025	10	4	15	13	31	32.8	-2.5	1.078	0.4	0.3	0	48.2	50.3	0	139	143	0	27	26
2025	10	4	15	23	31	33.5	-1.4	1.078	0.4	0.3	0	48.2	50.3	0	139	144	0	27	27
2025	10	4	15	33	31	32.8	-1.2	1.077	0.5	0.4	0	48.6	50.3	0	139	144	0	26	27
2025	10	4	15	43	31	32.8	-1.3	1.078	0.5	0.5	0	48.6	50.7	0	140	145	0	27	27
2025	10	4	15	53	31	32.6	-1.2	1.078	0.4	0.3	0	48.6	50.3	0	139	144	0	26	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	4	16	3	31	32.7	-0.8	1.077	0.4	0.3	0	48.6	50.3	0	139	144	0	26	27
2025	10	4	16	13	31	33.5	-2.1	1.077	0.4	0.3	0	48.2	50.3	0	139	144	0	27	27
2025	10	4	16	23	31	33.8	-2.1	1.077	0.5	0.4	0	49	50.7	0	140	145	0	26	27
2025	10	4	16	33	31	32.2	-1.1	1.077	0.4	0.3	0	48.6	50.7	0	139	144	0	26	26
2025	10	4	16	43	31	32.2	-1.4	1.077	0.5	0.4	0	49	50.7	0	140	145	0	26	27
2025	10	4	16	53	31	34.3	-1.8	1.077	0.4	0.3	0	48.2	50.3	0	139	144	0	27	27
2025	10	4	17	3	31	33.1	-1.3	1.076	0.3	0.2	0	49	50.7	0	140	145	0	26	27
2025	10	4	17	13	31	33.5	-1	1.077	0.4	0.3	0	48.6	51.2	0	140	145	0	27	26
2025	10	4	17	23	31	33.5	-2	1.076	0.4	0.3	0	48.6	50.3	0	139	144	0	26	27
2025	10	4	17	33	31	34	-1.3	1.077	0.4	0.3	0	48.2	50.3	0	139	144	0	27	27
2025	10	4	17	43	31	33	-1.2	1.077	0.3	0.2	0	47.7	50.7	0	138	144	0	27	26
2025	10	4	17	53	31	32.9	-0.9	1.077	0.4	0.3	0	47.7	49.9	0	138	143	0	27	27
2025	10	4	18	3	31	32.7	-1.3	1.077	0.4	0.3	0	47.7	49.9	0	137	143	0	26	27
2025	10	4	18	13	31	33.2	-1.9	1.077	0.5	0.4	0	47.7	49.9	0	137	143	0	26	27
2025	10	4	18	23	31	33.4	-1.7	1.077	0.4	0.3	0	47.7	50.3	0	138	144	0	27	27
2025	10	4	18	33	31	32.8	-2	1.077	0.5	0.4	0	48.6	50.7	0	139	145	0	26	27
2025	10	4	18	43	31	32.6	-1.7	1.077	0.3	0.2	0	48.6	50.3	0	139	144	0	26	27
2025	10	4	18	53	31	33.3	-0.9	1.077	0.4	0.3	0	49	51.2	0	141	146	0	27	27
2025	10	4	19	3	31	33.4	-1.1	1.078	0.5	0.4	0	49	51.2	0	140	146	0	26	27
2025	10	4	19	13	31	33	-1.6	1.078	0.5	0.4	0	49	52	0	141	147	0	27	26
2025	10	4	19	23	31	33.6	-2.8	1.078	0.5	0.4	0	49.9	51.6	0	142	147	0	26	27
2025	10	4	19	33	31	33	-1.7	1.078	0.4	0.3	0	49.5	51.2	0	142	147	0	27	28
2025	10	4	19	43	31	34.3	-1.5	1.078	0.4	0.3	0	49.5	51.6	0	142	147	0	27	27
2025	10	4	19	53	31	33.6	-0.2	1.078	0.4	0.3	0	50.3	51.6	0	143	148	0	26	28
2025	10	4	20	3	31	32.3	-1.3	1.078	0.4	0.3	0	50.3	52	0	143	148	0	26	27
2025	10	4	20	13	31	32.6	-1.2	1.078	0.4	0.3	0	50.3	52.5	0	144	149	0	27	27
2025	10	4	20	23	31	33.3	-1.8	1.078	0.4	0.3	0	49.9	52	0	143	148	0	27	27
2025	10	4	20	33	31	34.2	-0.9	1.078	0.3	0.2	0	49.9	52	0	143	148	0	27	27
2025	10	4	20	43	31	34.7	-1	1.078	0.4	0.3	0	49.9	52	0	144	149	0	28	28
2025	10	4	20	53	31	33	-1.3	1.078	0.4	0.3	0	50.3	52.5	0	144	149	0	27	27
2025	10	4	21	3	31	33.5	-2.5	1.078	0.5	0.4	0	50.3	52	0	143	148	0	26	27
2025	10	4	21	13	31	33.2	-0.7	1.078	0.3	0.2	0	50.3	52.5	0	144	149	0	27	27
2025	10	4	21	23	31	33.3	-0.4	1.078	0.4	0.3	0	50.3	53.3	0	144	150	0	27	26
2025	10	4	21	33	31	33.1	-1.2	1.078	0.3	0.2	0	50.7	52.9	0	145	150	0	27	27
2025	10	4	21	43	31	32.8	-1	1.077	0.3	0.2	0	50.7	52.9	0	145	150	0	27	27
2025	10	4	21	53	31	33.6	-1.1	1.078	0.4	0.3	0	50.3	52.5	0	144	149	0	27	27
2025	10	4	22	3	31	32.8	-1.7	1.078	0.4	0.3	0	50.3	52.5	0	144	149	0	27	27
2025	10	4	22	13	31	33.9	-1	1.078	0.3	0.2	0	51.2	52.9	0	145	150	0	26	27
2025	10	4	22	23	31	33.3	-1.3	1.078	0.4	0.3	0	51.2	52.9	0	145	150	0	26	27
2025	10	4	22	33	31	32.7	-1.6	1.078	0.4	0.3	0	50.7	52.9	0	145	150	0	27	27
2025	10	4	22	43	31	33.2	-1.3	1.078	0.5	0.4	0	50.7	53.3	0	145	150	0	27	26
2025	10	4	22	53	31	33.7	-2.5	1.078	0.3	0.2	0	50.3	52.9	0	144	150	0	27	27
2025	10	4	23	3	31	33.3	-0.6	1.078	0.4	0.3	0	50.7	53.3	0	145	151	0	27	27
2025	10	4	23	13	31	33	-1.7	1.078	0.4	0.3	0	50.7	52.9	0	145	150	0	27	27
2025	10	4	23	23	31	31.4	-0.5	1.077	0.4	0.3	0	50.7	53.3	0	145	151	0	27	27
2025	10	4	23	33	31	33.3	-1.4	1.078	0.3	0.2	0	51.2	52.9	0	145	150	0	26	27
2025	10	4	23	43	31	33.2	-1.2	1.078	0.3	0.2	0	51.2	52.9	0	145	150	0	26	27
2025	10	4	23	53	31	33.9	-0.9	1.078	0.3	0.2	0	51.2	52.9	0	145	150	0	26	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	5	0	3	31	32.4	-0.4	1.078	0.5	0.4	0	51.2	52.9	0	145	150	0	26	27
2025	10	5	0	13	31	33.6	-1.9	1.078	0.3	0.2	0	51.2	52.9	0	145	150	0	26	27
2025	10	5	0	23	31	32.6	-2.4	1.078	0.4	0.3	0	51.2	53.3	0	145	150	0	26	26
2025	10	5	0	33	31	33	-0.8	1.078	0.4	0.3	0	50.7	52.9	0	145	150	0	27	27
2025	10	5	0	43	31	33.8	-2	1.078	0.4	0.3	0	50.7	52.9	0	144	150	0	26	27
2025	10	5	0	53	31	33.2	-1.2	1.077	0.5	0.4	0	50.7	52.9	0	145	150	0	27	27
2025	10	5	1	3	31	32.4	-0.4	1.078	0.4	0.3	0	51.2	53.3	0	145	151	0	26	27
2025	10	5	1	13	31	33.3	-2.2	1.078	0.4	0.3	0	52.9	52.9	0	150	150	0	27	27
2025	10	5	1	23	31	33.5	-1.2	1.078	0.4	0.3	0	52.5	52.5	0	149	150	0	27	28
2025	10	5	1	33	31	32.4	-1.3	1.078	0.5	0.4	0	52.5	52.9	0	150	150	0	28	27
2025	10	5	1	43	31	33.3	-1.7	1.078	0.4	0.3	0	52.9	52.5	0	149	150	0	26	28
2025	10	5	1	53	31	33.2	-1	1.078	0.4	0.3	0	52.9	52.9	0	150	150	0	27	27
2025	10	5	2	3	31	33.4	-1.3	1.078	0.4	0.3	0	53.3	53.3	0	150	151	0	26	27
2025	10	5	2	13	31	33.3	-0.9	1.078	0.3	0.2	0	53.3	52.9	0	150	151	0	26	28
2025	10	5	2	23	31	32.5	-0.8	1.078	0.3	0.2	0	53.3	53.3	0	150	151	0	26	27
2025	10	5	2	33	31	34	-2	1.078	0.3	0.2	0	52.9	53.3	0	150	150	0	27	26
2025	10	5	2	43	31	32.9	-0.9	1.078	0.4	0.3	0	53.3	53.3	0	150	151	0	26	27
2025	10	5	2	53	31	33.1	-1.4	1.078	0.5	0.4	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	3	3	31	32.8	-2.2	1.078	0.4	0.3	0	52.9	52.9	0	150	150	0	27	27
2025	10	5	3	13	31	33.2	-0.7	1.078	0.5	0.5	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	3	23	31	32.5	-1	1.078	0.3	0.2	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	3	33	31	33	-1.5	1.078	0.4	0.3	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	3	43	31	33.6	-1.6	1.078	0.3	0.2	0	52.9	52.9	0	150	150	0	27	27
2025	10	5	3	53	31	33.2	-1.7	1.078	0.5	0.4	0	52.9	52.9	0	150	150	0	27	27
2025	10	5	4	3	31	33.2	-1.1	1.078	0.4	0.3	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	4	13	31	33.9	-0.3	1.078	0.4	0.3	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	4	23	31	33.2	-1.4	1.078	0.3	0.2	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	4	33	31	33.6	-1.6	1.078	0.3	0.2	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	4	43	31	33.6	-0.8	1.078	0.4	0.3	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	4	53	31	32.9	-0.4	1.078	0.4	0.3	0	53.3	53.8	0	151	152	0	27	27
2025	10	5	5	3	31	33.4	-2.4	1.078	0.5	0.5	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	5	13	31	33.1	-1.3	1.078	0.4	0.3	0	53.3	53.3	0	151	151	0	27	27
2025	10	5	5	23	31	33.3	-1.2	1.078	0.4	0.3	0	53.3	53.3	0	151	151	0	27	27
2025	10	5	5	33	31	33	-2.4	1.078	0.5	0.4	0	53.3	53.3	0	151	151	0	27	27
2025	10	5	5	43	31	33.5	-1.5	1.078	0.3	0.2	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	5	53	31	33.1	-1.6	1.078	0.3	0.2	0	53.3	53.3	0	150	151	0	26	27
2025	10	5	6	3	31	34.2	-1.7	1.078	0.5	0.4	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	6	13	31	33.6	-1.5	1.078	0.3	0.2	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	6	23	31	33.7	-1.6	1.078	0.5	0.4	0	53.3	53.3	0	150	151	0	26	27
2025	10	5	6	33	31	33.5	-1	1.078	0.4	0.3	0	52.9	52.9	0	150	151	0	27	28
2025	10	5	6	43	31	33.4	-1.1	1.078	0.3	0.2	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	6	53	31	33.6	-1.2	1.079	0.3	0.2	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	7	3	31	33.3	-1.5	1.079	0.5	0.4	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	7	13	31	33.8	-1.8	1.079	0.3	0.2	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	7	23	31	34.1	-1.1	1.079	0.3	0.2	0	52.5	52.5	0	149	150	0	27	28
2025	10	5	7	33	31	33.8	-1.3	1.079	0.4	0.3	0	51.6	52.5	0	148	150	0	28	28
2025	10	5	7	43	31	33	-1.6	1.079	0.4	0.3	0	52.9	52.9	0	149	150	0	26	27
2025	10	5	7	53	31	32.9	-2.1	1.079	0.4	0.3	0	52.5	52.9	0	149	150	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	5	8	3	31	32.9	-2.1	1.079	0.3	0.2	0	52.5	52.9	0	149	150	0	27	27
2025	10	5	8	13	31	32.9	-1.3	1.08	0.4	0.3	0	52	52.5	0	148	150	0	27	28
2025	10	5	8	23	31	33.8	-0.9	1.08	0.4	0.3	0	52.5	52	0	148	149	0	26	28
2025	10	5	8	33	31	33.3	-1.6	1.081	0.3	0.2	0	51.6	52.5	0	147	149	0	27	27
2025	10	5	8	43	31	33.7	-2.1	1.081	0.5	0.4	0	51.6	52.5	0	147	149	0	27	27
2025	10	5	8	53	31	33.1	-1.3	1.082	0.4	0.3	0	51.6	52	0	147	148	0	27	27
2025	10	5	9	3	31	33.1	-1.5	1.082	0.4	0.3	0	51.2	52	0	146	147	0	27	26
2025	10	5	9	13	31	33.9	-1.2	1.082	0.5	0.5	0	51.6	51.2	0	146	147	0	26	28
2025	10	5	9	23	31	34.1	-1.8	1.083	0.5	0.4	0	50.7	51.6	0	145	147	0	27	27
2025	10	5	9	33	31	32.9	-1.9	1.083	0.6	0.5	0	50.7	51.2	0	145	146	0	27	27
2025	10	5	9	43	31	34	-1.4	1.083	0.5	0.4	0	49.9	51.2	0	144	146	0	28	27
2025	10	5	9	53	31	33.4	-0.7	1.083	0.5	0.4	0	50.3	50.7	0	144	146	0	27	28
2025	10	5	10	3	31	33.1	-2.1	1.083	0.5	0.4	0	50.3	50.7	0	144	145	0	27	27
2025	10	5	10	13	31	34.1	-2.9	1.083	0.3	0.2	0	50.3	50.7	0	144	146	0	27	28
2025	10	5	10	23	31	32.6	-0.5	1.083	0.3	0.2	0	50.3	50.7	0	144	146	0	27	28
2025	10	5	10	33	31	34.2	-1.7	1.083	0.3	0.2	0	50.3	50.3	0	144	145	0	27	28
2025	10	5	10	43	31	34.1	-1.8	1.083	0.3	0.2	0	50.3	50.7	0	144	145	0	27	27
2025	10	5	10	53	31	33	-1.4	1.083	0.3	0.2	0	49.9	50.7	0	144	146	0	28	28
2025	10	5	11	3	31	33.6	-1.3	1.083	0.5	0.5	0	50.3	51.2	0	144	146	0	27	27
2025	10	5	11	13	31	33.8	-2.7	1.083	0.5	0.4	0	49.9	50.7	0	143	145	0	27	27
2025	10	5	11	23	31	33.9	-1.3	1.084	0.5	0.4	0	50.3	51.2	0	144	146	0	27	27
2025	10	5	11	33	31	34.1	-2	1.083	0.5	0.5	0	49.9	50.3	0	143	145	0	27	28
2025	10	5	11	43	31	33.7	-1.6	1.083	0.4	0.3	0	49.9	50.7	0	143	145	0	27	27
2025	10	5	11	53	31	34.9	-1.3	1.082	0.4	0.3	0	49.9	50.7	0	143	145	0	27	27
2025	10	5	12	3	31	34.1	-1.8	1.083	0.4	0.3	0	49.9	50.7	0	143	145	0	27	27
2025	10	5	12	13	31	33	-2.1	1.083	0.4	0.3	0	49.9	50.7	0	143	145	0	27	27
2025	10	5	12	23	31	34	-2	1.083	0.5	0.4	0	49.9	50.7	0	143	145	0	27	27
2025	10	5	12	33	31	32.6	-1.9	1.082	0.4	0.3	0	49.9	50.3	0	143	144	0	27	27
2025	10	5	12	43	31	34.7	-2	1.083	0.4	0.3	0	49	50.3	0	142	144	0	28	27
2025	10	5	12	53	31	33.2	-1.2	1.083	0.4	0.3	0	49.9	50.7	0	143	145	0	27	27
2025	10	5	13	3	31	34.1	-1.6	1.083	0.5	0.4	0	49.5	50.3	0	142	144	0	27	27
2025	10	5	13	13	31	33.7	-1.8	1.083	0.5	0.4	0	49.5	50.3	0	142	144	0	27	27
2025	10	5	13	23	31	34	-2.6	1.083	0.5	0.4	0	49.5	50.3	0	142	144	0	27	27
2025	10	5	13	33	31	32.7	-0.8	1.083	0.3	0.2	0	49.9	50.7	0	143	145	0	27	27
2025	10	5	13	43	31	33.9	-1.3	1.083	0.4	0.3	0	50.3	51.2	0	144	146	0	27	27
2025	10	5	13	53	31	33.8	-1.4	1.083	0.3	0.2	0	50.3	50.7	0	143	145	0	26	27
2025	10	5	14	3	31	33.5	-1.4	1.083	0.3	0.2	0	49.9	50.7	0	143	145	0	27	27
2025	10	5	14	13	31	34.4	-0.8	1.083	0.5	0.5	0	49.5	50.3	0	142	144	0	27	27
2025	10	5	14	23	31	33.9	-1.9	1.083	0.3	0.2	0	49.9	50.7	0	143	145	0	27	27
2025	10	5	14	33	31	33	-1.9	1.083	0.4	0.3	0	50.3	51.2	0	144	146	0	27	27
2025	10	5	14	43	31	34.5	-2.1	1.084	0.4	0.3	0	49.9	51.2	0	143	146	0	27	27
2025	10	5	14	53	31	34.4	-1.6	1.083	0.5	0.4	0	50.3	51.6	0	143	146	0	26	26
2025	10	5	15	3	31	33.2	-2.3	1.084	0.4	0.3	0	49.9	50.7	0	143	145	0	27	27
2025	10	5	15	13	31	34.9	-0.2	1.084	0.3	0.2	0	49.9	50.7	0	143	145	0	27	27
2025	10	5	15	23	31	33.7	-1.5	1.084	0.5	0.4	0	49	49.9	0	140	143	0	26	27
2025	10	5	15	33	31	34.3	-1.2	1.084	0.3	0.2	0	49	49.9	0	141	143	0	27	27
2025	10	5	15	43	31	33.4	-1.5	1.084	0.5	0.4	0	48.6	49.9	0	140	143	0	27	27
2025	10	5	15	53	31	34.1	-2.1	1.084	0.4	0.3	0	48.6	49.9	0	140	143	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	5	16	3	31	33.6	-2	1.084	0.4	0.3	0	49.5	50.7	0	142	145	0	27	27
2025	10	5	16	13	31	33.6	-2	1.085	0.5	0.4	0	49.5	49.9	0	142	144	0	27	28
2025	10	5	16	23	31	33.5	-1.4	1.084	0.5	0.4	0	49	50.3	0	141	144	0	27	27
2025	10	5	16	33	31	32.3	-1	1.084	0.3	0.2	0	49.5	50.7	0	142	145	0	27	27
2025	10	5	16	43	31	32.8	-1.5	1.085	0.4	0.3	0	49	51.2	0	141	145	0	27	26
2025	10	5	16	53	31	33.9	-0.8	1.085	0.3	0.2	0	49.5	50.7	0	142	145	0	27	27
2025	10	5	17	3	31	33.3	-2.1	1.085	0.4	0.3	0	49.5	50.7	0	142	145	0	27	27
2025	10	5	17	13	31	34.5	-2.2	1.085	0.4	0.3	0	49.9	50.7	0	143	145	0	27	27
2025	10	5	17	23	31	34.2	-0.5	1.085	0.5	0.5	0	49.9	51.2	0	143	146	0	27	27
2025	10	5	17	33	31	33.7	-2.2	1.086	0.3	0.2	0	49.9	51.2	0	143	146	0	27	27
2025	10	5	17	43	31	34.2	-1.6	1.085	0.4	0.3	0	49	51.2	0	141	145	0	27	26
2025	10	5	17	53	31	33.5	-1.3	1.086	0.4	0.3	0	49.9	50.7	0	142	145	0	26	27
2025	10	5	18	3	31	33.8	-1.9	1.086	0.5	0.4	0	49.9	51.2	0	143	146	0	27	27
2025	10	5	18	13	31	33.8	-0.9	1.087	0.4	0.3	0	49.5	50.7	0	142	145	0	27	27
2025	10	5	18	23	31	33.8	-1.3	1.087	0.5	0.4	0	49.9	51.2	0	143	146	0	27	27
2025	10	5	18	33	31	34.4	-1.8	1.087	0.5	0.4	0	49.9	51.2	0	143	146	0	27	27
2025	10	5	18	43	31	34.2	-0.8	1.088	0.4	0.3	0	50.7	51.6	0	144	147	0	26	27
2025	10	5	18	53	31	34.3	-0.3	1.088	0.5	0.4	0	50.7	51.6	0	144	147	0	26	27
2025	10	5	19	3	31	33.4	-1.3	1.088	0.3	0.2	0	50.7	51.6	0	144	147	0	26	27
2025	10	5	19	13	31	33.4	-0.7	1.088	0.4	0.3	0	51.2	52.5	0	145	148	0	26	26
2025	10	5	19	23	31	33.9	-1.8	1.088	0.5	0.4	0	50.7	52	0	145	148	0	27	27
2025	10	5	19	33	31	33.9	-1.8	1.089	0.4	0.3	0	51.6	52.9	0	146	150	0	26	27
2025	10	5	19	43	31	33.2	-1.7	1.089	0.5	0.5	0	51.6	52.5	0	146	149	0	26	27
2025	10	5	19	53	31	32.8	-0.8	1.088	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	5	20	3	31	34.1	-1.4	1.089	0.4	0.3	0	51.6	52.5	0	146	149	0	26	27
2025	10	5	20	13	31	33.6	-1.4	1.089	0.4	0.3	0	52	52.9	0	147	150	0	26	27
2025	10	5	20	23	31	34.1	-2.2	1.089	0.4	0.3	0	51.2	52.9	0	147	150	0	28	27
2025	10	5	20	33	31	33.4	-1.8	1.089	0.5	0.4	0	51.6	53.3	0	147	150	0	27	26
2025	10	5	20	43	31	34.2	-0.8	1.089	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	5	20	53	31	34.4	-1	1.089	0.5	0.5	0	51.6	52.9	0	147	150	0	27	27
2025	10	5	21	3	31	34	-1.1	1.089	0.5	0.4	0	51.6	52.5	0	147	150	0	27	28
2025	10	5	21	13	31	33.6	-1.8	1.089	0.5	0.4	0	52	53.3	0	147	150	0	26	26
2025	10	5	21	23	31	32.3	-1.6	1.089	0.5	0.4	0	51.6	53.3	0	147	151	0	27	27
2025	10	5	21	33	31	33.2	-1	1.089	0.4	0.3	0	51.6	53.8	0	147	151	0	27	26
2025	10	5	21	43	31	34.8	-2.7	1.089	0.3	0.2	0	52	52.9	0	147	150	0	26	27
2025	10	5	21	53	31	34	-1.2	1.089	0.4	0.3	0	51.6	53.3	0	147	151	0	27	27
2025	10	5	22	3	31	34.3	-1.2	1.089	0.5	0.4	0	51.6	53.3	0	147	151	0	27	27
2025	10	5	22	13	31	33.7	-1.8	1.089	0.3	0.2	0	52	53.3	0	147	151	0	26	27
2025	10	5	22	23	31	34.8	-1.4	1.089	0.4	0.3	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	22	33	31	33.6	-1.6	1.089	0.5	0.4	0	53.3	52.9	0	150	151	0	26	28
2025	10	5	22	43	31	33.7	-1.5	1.089	0.4	0.3	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	22	53	31	33	-1.3	1.089	0.5	0.4	0	52.9	52.9	0	150	151	0	27	28
2025	10	5	23	3	31	33.5	-1.2	1.089	0.4	0.3	0	53.3	53.3	0	151	151	0	27	27
2025	10	5	23	13	31	34.2	-2	1.089	0.5	0.4	0	53.3	53.3	0	150	151	0	26	27
2025	10	5	23	23	31	33.5	-1.7	1.09	0.5	0.4	0	53.3	53.8	0	151	152	0	27	27
2025	10	5	23	33	31	34.3	-2.5	1.09	0.5	0.4	0	52.9	53.8	0	150	151	0	27	26
2025	10	5	23	43	31	33.1	-2.1	1.089	0.5	0.4	0	52.9	53.3	0	150	151	0	27	27
2025	10	5	23	53	31	33.4	-1.7	1.089	0.4	0.3	0	52.9	53.8	0	150	152	0	27	27

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	6	0	3	31	34.7	-2	1.09	0.5	0.4	0	52.9	53.3	0	150	151	0	27	27
2025	10	6	0	13	31	33.3	-1.1	1.09	0.5	0.4	0	52.9	53.8	0	150	152	0	27	27
2025	10	6	0	23	31	34.7	-1.7	1.09	0.5	0.4	0	53.3	53.8	0	151	152	0	27	27
2025	10	6	0	33	31	34.1	-1.1	1.09	0.3	0.2	0	53.3	53.8	0	151	152	0	27	27
2025	10	6	0	43	31	32.9	-1.2	1.09	0.3	0.2	0	53.3	53.8	0	151	152	0	27	27
2025	10	6	0	53	31	33.6	-0.9	1.09	0.3	0.2	0	52.9	54.2	0	150	152	0	27	26
2025	10	6	1	3	31	34.3	-1.2	1.09	0.5	0.4	0	52.9	54.2	0	150	152	0	27	26
2025	10	6	1	13	31	33.7	-0.5	1.09	0.5	0.4	0	53.3	53.8	0	150	152	0	26	27
2025	10	6	1	23	31	34	-0.5	1.09	0.5	0.4	0	52.9	53.8	0	150	152	0	27	27
2025	10	6	1	33	31	34	-1.2	1.09	0.3	0.2	0	53.8	53.8	0	151	152	0	26	27
2025	10	6	1	43	31	34	-1.5	1.09	0.4	0.3	0	53.3	53.8	0	151	152	0	27	27
2025	10	6	1	53	31	35.1	-1.8	1.09	0.4	0.3	0	52.9	53.8	0	150	152	0	27	27
2025	10	6	2	3	31	33.2	-0.7	1.09	0.5	0.5	0	53.3	53.8	0	150	152	0	26	27
2025	10	6	2	13	31	34.1	-1.4	1.09	0.3	0.2	0	53.3	53.8	0	151	152	0	27	27
2025	10	6	2	23	31	33.8	-2.5	1.09	0.3	0.2	0	53.3	53.8	0	151	152	0	27	27
2025	10	6	2	33	31	34	-1.2	1.09	0.3	0.2	0	53.3	53.8	0	151	152	0	27	27
2025	10	6	2	43	31	34.6	-2.3	1.09	0.4	0.3	0	52.9	53.8	0	150	152	0	27	27
2025	10	6	2	53	31	34.7	-1.7	1.09	0.3	0.2	0	52.9	53.8	0	150	152	0	27	27
2025	10	6	3	3	31	33.8	-1.2	1.09	0.3	0.2	0	53.3	53.8	0	151	152	0	27	27
2025	10	6	3	13	31	34.5	-1.4	1.09	0.5	0.4	0	52.9	53.8	0	150	152	0	27	27
2025	10	6	3	23	31	33.2	-1.5	1.09	0.3	0.2	0	53.3	53.8	0	151	152	0	27	27
2025	10	6	3	33	31	34.1	-1.1	1.09	0.3	0.2	0	53.3	54.2	0	151	153	0	27	27
2025	10	6	3	43	31	34.4	-1.1	1.09	0.5	0.4	0	52.9	53.8	0	150	152	0	27	27
2025	10	6	3	53	31	34.1	-2.1	1.09	0.4	0.3	0	53.3	53.8	0	151	152	0	27	27
2025	10	6	4	3	31	34.2	-1.4	1.09	0.3	0.2	0	53.3	53.8	0	151	153	0	27	28
2025	10	6	4	13	31	34.2	-2.1	1.09	0.5	0.4	0	53.3	54.2	0	151	153	0	27	27
2025	10	6	4	23	31	33.8	-1.5	1.09	0.3	0.2	0	53.3	53.8	0	151	153	0	27	28
2025	10	6	4	33	31	34	-1.5	1.09	0.4	0.3	0	53.3	54.2	0	151	153	0	27	27
2025	10	6	4	43	31	33.3	-1.5	1.09	0.3	0.2	0	53.3	53.8	0	151	153	0	27	28
2025	10	6	4	53	31	33.7	-2.1	1.09	0.3	0.2	0	53.3	54.2	0	151	153	0	27	27
2025	10	6	5	3	31	33.8	-2.3	1.09	0.4	0.3	0	53.3	54.2	0	151	153	0	27	27
2025	10	6	5	13	31	34.7	-0.6	1.09	0.4	0.3	0	53.3	54.2	0	151	153	0	27	27
2025	10	6	5	23	31	33.8	-1.8	1.09	0.4	0.3	0	53.3	54.2	0	151	153	0	27	27
2025	10	6	5	33	31	34.6	-0.8	1.09	0.4	0.3	0	53.3	54.2	0	151	153	0	27	27
2025	10	6	5	43	31	33.5	-1.5	1.09	0.5	0.4	0	53.3	54.2	0	150	153	0	26	27
2025	10	6	5	53	31	33.6	-1.7	1.09	0.3	0.2	0	53.3	53.8	0	151	153	0	27	28
2025	10	6	6	3	31	33.3	-1.5	1.09	0.4	0.3	0	53.3	54.2	0	151	153	0	27	27
2025	10	6	6	13	31	34.8	-3.7	1.09	0.4	0.3	0	53.3	53.8	0	151	153	0	27	28
2025	10	6	6	23	31	33.7	-1.3	1.09	0.3	0.2	0	53.3	54.2	0	151	153	0	27	27
2025	10	6	6	33	31	34.4	-1.3	1.09	0.3	0.2	0	52.9	54.6	0	151	153	0	28	26
2025	10	6	6	43	31	34	-1.3	1.09	0.6	0.5	0	52.9	54.6	0	150	153	0	27	26
2025	10	6	6	53	31	33.7	-1.9	1.09	0.4	0.3	0	53.3	54.2	0	151	153	0	27	27
2025	10	6	7	3	31	35	-2.4	1.091	0.4	0.3	0	53.3	54.2	0	151	153	0	27	27
2025	10	6	7	13	31	34.4	-2.1	1.09	0.4	0.3	0	52.9	53.8	0	150	152	0	27	27
2025	10	6	7	23	31	32.9	0	1.09	0.3	0.2	0	53.3	54.2	0	151	153	0	27	27
2025	10	6	7	33	31	34.8	-1.3	1.091	0.3	0.2	0	52.9	53.8	0	150	152	0	27	27
2025	10	6	7	43	31	33.1	-1.1	1.091	0.3	0.2	0	52.9	54.2	0	150	153	0	27	27
2025	10	6	7	53	31	33.1	-1.3	1.091	0.3	0.2	0	52.9	53.8	0	150	152	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	6	8	3	31	33.8	-1.3	1.091	0.5	0.4	0	52.9	54.2	0	150	153	0	27	27
2025	10	6	8	13	31	34.2	-2.1	1.091	0.4	0.3	0	53.3	53.3	0	150	152	0	26	28
2025	10	6	8	23	31	34.3	-2.1	1.091	0.4	0.3	0	52.5	53.3	0	150	152	0	28	28
2025	10	6	8	33	31	35	-2.2	1.091	0.5	0.5	0	52.5	52.9	0	149	151	0	27	28
2025	10	6	8	43	31	33.9	-1.5	1.091	0.4	0.3	0	52.5	53.8	0	149	152	0	27	27
2025	10	6	8	53	31	33.9	-1.2	1.091	0.5	0.4	0	52.5	53.8	0	149	151	0	27	26
2025	10	6	9	3	31	33.9	-1.6	1.091	0.3	0.2	0	52	52.9	0	148	151	0	27	28
2025	10	6	9	13	31	34.3	-0.5	1.091	0.3	0.2	0	52	52.9	0	148	150	0	27	27
2025	10	6	9	23	31	33.9	-0.7	1.091	0.4	0.3	0	52	52.5	0	148	150	0	27	28
2025	10	6	9	33	31	33.6	-1.6	1.091	0.4	0.3	0	52	52.9	0	148	150	0	27	27
2025	10	6	9	43	31	33.1	-1.7	1.091	0.3	0.2	0	52	52.9	0	148	150	0	27	27
2025	10	6	9	53	31	33.3	-0.7	1.091	0.4	0.3	0	52	53.3	0	148	151	0	27	27
2025	10	6	10	3	31	33	-2	1.091	0.5	0.4	0	52	52.9	0	148	150	0	27	27
2025	10	6	10	13	31	33	-1.5	1.091	0.4	0.3	0	52	53.3	0	148	151	0	27	27
2025	10	6	10	23	31	33.5	-2.1	1.091	0.3	0.2	0	52.5	53.3	0	149	151	0	27	27
2025	10	6	10	33	31	34.5	-1.3	1.091	0.3	0.2	0	52	53.3	0	148	151	0	27	27
2025	10	6	10	43	31	33.9	-1.1	1.091	0.5	0.4	0	52	53.8	0	148	151	0	27	26
2025	10	6	10	53	31	33	-2.3	1.091	0.5	0.4	0	52	53.3	0	148	151	0	27	27
2025	10	6	11	3	31	34.9	-1.8	1.091	0.5	0.4	0	52.5	52.9	0	148	150	0	26	27
2025	10	6	11	13	31	34.3	-0.5	1.091	0.3	0.2	0	52	53.3	0	148	151	0	27	27
2025	10	6	11	23	31	34	-1.3	1.091	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	6	11	33	31	33	-1.2	1.091	0.4	0.3	0	52	53.3	0	148	151	0	27	27
2025	10	6	11	43	31	33.9	-1.6	1.091	0.3	0.2	0	52	53.3	0	148	151	0	27	27
2025	10	6	11	53	31	32.8	-1.3	1.091	0.5	0.4	0	52	53.3	0	148	151	0	27	27
2025	10	6	12	3	31	34.6	-1	1.091	0.5	0.4	0	52	53.3	0	148	151	0	27	27
2025	10	6	12	13	31	33.6	-1.1	1.091	0.4	0.3	0	52	52.9	0	147	150	0	26	27
2025	10	6	12	23	31	33.9	-1	1.091	0.3	0.2	0	51.6	52.9	0	147	150	0	27	27
2025	10	6	12	33	31	34.4	-1.1	1.091	0.5	0.4	0	51.6	52.9	0	147	150	0	27	27
2025	10	6	12	43	31	34.3	-2.1	1.091	0.3	0.2	0	51.2	52	0	146	149	0	27	28
2025	10	6	12	53	31	32.7	-1.7	1.091	0.5	0.4	0	51.2	52.9	0	146	150	0	27	27
2025	10	6	13	3	31	33.3	-0.8	1.091	0.5	0.4	0	51.2	52	0	146	149	0	27	28
2025	10	6	13	13	31	34.4	-1.9	1.092	0.3	0.2	0	51.2	52.5	0	146	149	0	27	27
2025	10	6	13	23	31	33.5	-1.4	1.092	0.3	0.2	0	51.2	52.5	0	146	149	0	27	27
2025	10	6	13	33	31	33.7	-1.8	1.092	0.5	0.4	0	51.6	52.5	0	146	149	0	26	27
2025	10	6	13	43	31	33.3	-1.3	1.092	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	6	13	53	31	33.8	-0.9	1.092	0.5	0.4	0	51.6	52.5	0	146	149	0	26	27
2025	10	6	14	3	31	34.1	-1.9	1.092	0.4	0.3	0	50.7	52.5	0	145	149	0	27	27
2025	10	6	14	13	31	33.8	-2.1	1.092	0.4	0.3	0	50.7	52.5	0	145	149	0	27	27
2025	10	6	14	23	31	33.8	-0.9	1.092	0.5	0.4	0	50.7	52.9	0	145	149	0	27	26
2025	10	6	14	33	31	34.2	-2.3	1.092	0.4	0.3	0	51.2	51.6	0	145	148	0	26	28
2025	10	6	14	43	31	34.2	-0.8	1.092	0.5	0.4	0	51.2	52.5	0	146	149	0	27	27
2025	10	6	14	53	31	33.8	-1.2	1.092	0.5	0.4	0	51.2	52.5	0	146	149	0	27	27
2025	10	6	15	3	31	33.4	-1.3	1.092	0.5	0.4	0	51.2	52.9	0	146	150	0	27	27
2025	10	6	15	13	31	33.3	-1.3	1.093	0.4	0.3	0	51.6	52.5	0	146	149	0	26	27
2025	10	6	15	23	31	34	-0.9	1.092	0.4	0.3	0	50.7	52.5	0	145	149	0	27	27
2025	10	6	15	33	31	33.4	-1.7	1.092	0.5	0.4	0	51.2	52.5	0	146	149	0	27	27
2025	10	6	15	43	31	34.3	-1.5	1.092	0.3	0.2	0	51.2	52.5	0	145	149	0	26	27
2025	10	6	15	53	31	33.5	-2.2	1.092	0.4	0.3	0	50.7	52.5	0	145	149	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	6	16	3	31	35.1	-1.2	1.092	0.5	0.5	0	51.6	52.9	0	146	149	0	26	26
2025	10	6	16	13	31	33.1	-1.4	1.092	0.4	0.3	0	51.2	52	0	146	149	0	27	28
2025	10	6	16	23	31	34.4	-0.9	1.092	0.4	0.3	0	50.7	52.5	0	145	149	0	27	27
2025	10	6	16	33	31	34.1	-2.8	1.092	0.4	0.3	0	51.2	52.5	0	145	149	0	26	27
2025	10	6	16	43	31	34.7	-1.6	1.093	0.5	0.4	0	50.7	52.5	0	145	149	0	27	27
2025	10	6	16	53	31	33.1	-1.8	1.093	0.5	0.4	0	51.2	52.9	0	145	149	0	26	26
2025	10	6	17	3	31	33.2	-2.1	1.092	0.5	0.4	0	51.2	52.5	0	145	149	0	26	27
2025	10	6	17	13	31	33.6	-1.7	1.093	0.4	0.3	0	51.2	53.3	0	146	150	0	27	26
2025	10	6	17	23	31	33.9	-1.9	1.093	0.4	0.3	0	51.2	52.9	0	146	149	0	27	26
2025	10	6	17	33	31	32.6	-1.3	1.093	0.3	0.2	0	51.6	52.5	0	146	149	0	26	27
2025	10	6	17	43	31	33.8	-1.3	1.093	0.3	0.2	0	51.6	52.5	0	146	149	0	26	27
2025	10	6	17	53	31	34.2	-0.9	1.093	0.4	0.3	0	50.7	52	0	144	148	0	26	27
2025	10	6	18	3	31	34.3	-2.1	1.093	0.3	0.2	0	50.3	52	0	144	148	0	27	27
2025	10	6	18	13	31	33.5	-1.2	1.093	0.3	0.2	0	50.7	52	0	145	148	0	27	27
2025	10	6	18	23	31	33.5	-1.5	1.093	0.5	0.4	0	51.2	52.9	0	145	149	0	26	26
2025	10	6	18	33	31	32.9	-1.6	1.093	0.4	0.3	0	50.3	52.5	0	144	148	0	27	26
2025	10	6	18	43	31	33.6	-1	1.093	0.3	0.2	0	50.7	52.9	0	145	149	0	27	26
2025	10	6	18	53	31	34.1	-2.3	1.093	0.4	0.3	0	50.3	52.5	0	144	148	0	27	26
2025	10	6	19	3	31	33.5	-2.4	1.093	0.5	0.4	0	50.3	52.9	0	144	149	0	27	26
2025	10	6	19	13	31	33.9	-1.3	1.093	0.4	0.3	0	50.7	52.5	0	145	149	0	27	27
2025	10	6	19	23	31	34.5	-1.9	1.093	0.4	0.3	0	52	53.3	0	148	150	0	27	26
2025	10	6	19	33	31	34	-0.9	1.093	0.3	0.2	0	53.3	52.5	0	150	150	0	26	28
2025	10	6	19	43	31	34.1	-0.7	1.093	0.5	0.4	0	52.9	52.9	0	150	150	0	27	27
2025	10	6	19	53	31	33.9	-1.2	1.093	0.5	0.4	0	53.3	53.3	0	150	151	0	26	27
2025	10	6	20	3	31	34.2	-2.4	1.093	0.3	0.2	0	53.3	52.9	0	150	150	0	26	27
2025	10	6	20	13	31	34.5	-1.6	1.093	0.5	0.4	0	53.3	53.3	0	151	151	0	27	27
2025	10	6	20	23	31	33.2	-1.7	1.092	0.5	0.5	0	53.8	53.3	0	151	151	0	26	27
2025	10	6	20	33	31	33.5	0.1	1.092	0.4	0.3	0	53.3	53.3	0	150	151	0	26	27
2025	10	6	20	43	31	33.6	-1.5	1.092	0.3	0.2	0	53.8	53.3	0	151	151	0	26	27
2025	10	6	20	53	31	33.8	-1.7	1.092	0.4	0.3	0	52.9	53.3	0	150	151	0	27	27
2025	10	6	21	3	31	32.9	-1.1	1.092	0.4	0.3	0	53.8	53.8	0	151	152	0	26	27
2025	10	6	21	13	31	33.9	-0.8	1.092	0.5	0.4	0	53.3	53.3	0	151	151	0	27	27
2025	10	6	21	23	31	33.9	-1.2	1.092	0.4	0.3	0	53.3	53.8	0	150	151	0	26	26
2025	10	6	21	33	31	34.4	-0.5	1.092	0.5	0.4	0	52.9	53.3	0	150	151	0	27	27
2025	10	6	21	43	31	34.4	-1.5	1.092	0.5	0.5	0	52.9	53.3	0	150	151	0	27	27
2025	10	6	21	53	31	34.1	-1.7	1.092	0.5	0.4	0	53.3	53.8	0	150	151	0	26	26
2025	10	6	22	3	31	34.8	-0.9	1.092	0.4	0.3	0	52.9	53.3	0	150	151	0	27	27
2025	10	6	22	13	31	34.8	-2.3	1.092	0.5	0.4	0	53.3	53.8	0	150	151	0	26	26
2025	10	6	22	23	31	34.5	-0.8	1.092	0.4	0.3	0	53.3	53.8	0	151	151	0	27	26
2025	10	6	22	33	31	33.2	-1.7	1.092	0.4	0.3	0	52.9	53.3	0	150	151	0	27	27
2025	10	6	22	43	31	33.2	-0.4	1.092	0.5	0.4	0	52.9	53.3	0	150	151	0	27	27
2025	10	6	22	53	31	33.5	-0.9	1.092	0.5	0.4	0	53.3	53.3	0	150	151	0	26	27
2025	10	6	23	3	31	33.6	-0.6	1.091	0.5	0.4	0	52.9	53.8	0	150	152	0	27	27
2025	10	6	23	13	31	33.8	-1.1	1.092	0.3	0.2	0	53.3	53.3	0	150	151	0	26	27
2025	10	6	23	23	31	34	-1	1.091	0.3	0.2	0	53.3	53.8	0	150	151	0	26	26
2025	10	6	23	33	31	33.9	-0.4	1.091	0.4	0.3	0	52.9	53.3	0	150	151	0	27	27
2025	10	6	23	43	31	34.3	-1.7	1.091	0.5	0.4	0	52.9	53.3	0	150	151	0	27	27
2025	10	6	23	53	31	33.6	-0.8	1.091	0.3	0.2	0	52.9	53.3	0	150	151	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	7	0	3	31	33.5	-1.6	1.091	0.4	0.3	0	53.3	53.3	0	151	151	0	27	27
2025	10	7	0	13	31	34.1	-0.9	1.091	0.5	0.4	0	52.9	53.3	0	150	152	0	27	28
2025	10	7	0	23	31	33	-0.9	1.091	0.3	0.2	0	52.9	53.8	0	150	151	0	27	26
2025	10	7	0	33	31	33	-0.5	1.091	0.3	0.2	0	52.9	53.8	0	150	152	0	27	27
2025	10	7	0	43	31	34.3	-1.4	1.091	0.5	0.4	0	52.9	53.3	0	150	151	0	27	27
2025	10	7	0	53	31	34.3	0	1.091	0.4	0.3	0	52.9	53.3	0	150	151	0	27	27
2025	10	7	1	3	31	34.4	-2.2	1.091	0.4	0.3	0	53.3	53.8	0	150	152	0	26	27
2025	10	7	1	13	31	32.8	-0.6	1.091	0.3	0.2	0	53.3	53.8	0	150	152	0	26	27
2025	10	7	1	23	31	34.1	-0.9	1.091	0.5	0.4	0	53.3	53.3	0	150	152	0	26	28
2025	10	7	1	33	31	34.1	-1.1	1.091	0.4	0.3	0	52.9	53.3	0	150	151	0	27	27
2025	10	7	1	43	31	33.7	-1	1.091	0.5	0.4	0	52.9	53.3	0	150	152	0	27	28
2025	10	7	1	53	31	33.5	-1.2	1.091	0.5	0.4	0	52.5	53.3	0	149	151	0	27	27
2025	10	7	2	3	31	34.5	-1.8	1.091	0.4	0.3	0	52.9	53.3	0	150	151	0	27	27
2025	10	7	2	13	31	34	-1.7	1.09	0.3	0.2	0	52.9	53.3	0	150	151	0	27	27
2025	10	7	2	23	31	33.5	-1.5	1.091	0.5	0.4	0	52.9	53.8	0	150	152	0	27	27
2025	10	7	2	33	31	32.9	-0.3	1.09	0.5	0.4	0	53.3	53.8	0	150	152	0	26	27
2025	10	7	2	43	31	33.3	-1.8	1.09	0.5	0.4	0	52.9	53.8	0	150	152	0	27	27
2025	10	7	2	53	31	34.2	-0.6	1.09	0.3	0.2	0	52.5	54.2	0	150	152	0	28	26
2025	10	7	3	3	31	35.2	-2.4	1.09	0.4	0.3	0	53.3	53.8	0	150	152	0	26	27
2025	10	7	3	13	31	33.9	-1.3	1.09	0.5	0.5	0	52.9	54.2	0	150	152	0	27	26
2025	10	7	3	23	31	35.4	-2.2	1.09	0.5	0.4	0	52	53.3	0	149	151	0	28	27
2025	10	7	3	33	31	34	-1.7	1.09	0.3	0.2	0	52.9	53.3	0	150	151	0	27	27
2025	10	7	3	43	31	34.1	-1.7	1.09	0.4	0.3	0	52.5	53.8	0	149	152	0	27	27
2025	10	7	3	53	31	34.5	-1.7	1.09	0.4	0.3	0	52.9	53.8	0	150	152	0	27	27
2025	10	7	4	3	31	34.5	-0.4	1.09	0.4	0.3	0	52.9	53.8	0	150	152	0	27	27
2025	10	7	4	13	31	34.2	-2.2	1.09	0.5	0.4	0	52.5	53.8	0	149	152	0	27	27
2025	10	7	4	23	31	33.4	-2.4	1.09	0.4	0.3	0	52.5	53.8	0	149	152	0	27	27
2025	10	7	4	33	31	34.4	-1.6	1.09	0.3	0.2	0	52.9	53.3	0	149	151	0	26	27
2025	10	7	4	43	31	34	-2.1	1.09	0.4	0.3	0	52	53.3	0	149	151	0	28	27
2025	10	7	4	53	31	35	-2.4	1.09	0.3	0.2	0	52.5	52.9	0	149	151	0	27	28
2025	10	7	5	3	31	33.6	-2.3	1.09	0.4	0.3	0	52.9	53.3	0	150	151	0	27	27
2025	10	7	5	13	31	34.2	-1.4	1.09	0.4	0.3	0	52.5	53.8	0	149	152	0	27	27
2025	10	7	5	23	31	33.8	-1.8	1.09	0.5	0.4	0	52.5	53.8	0	149	151	0	27	26
2025	10	7	5	33	31	35.1	-0.7	1.09	0.3	0.2	0	52.5	53.3	0	149	151	0	27	27
2025	10	7	5	43	31	34	-1.7	1.09	0.4	0.3	0	52.5	53.3	0	149	152	0	27	28
2025	10	7	5	53	31	33.9	-1.9	1.09	0.4	0.3	0	52.9	53.8	0	150	152	0	27	27
2025	10	7	6	3	31	34.5	-1.7	1.09	0.4	0.3	0	53.3	53.8	0	150	152	0	26	27
2025	10	7	6	13	31	34.5	-2	1.09	0.4	0.3	0	52.9	54.2	0	150	152	0	27	26
2025	10	7	6	23	31	33.1	-0.6	1.09	0.5	0.4	0	52.5	53.8	0	149	152	0	27	27
2025	10	7	6	33	31	34	-2.9	1.09	0.5	0.5	0	52.5	54.2	0	149	152	0	27	26
2025	10	7	6	43	31	34.3	-1.2	1.09	0.4	0.3	0	52.5	53.8	0	149	152	0	27	27
2025	10	7	6	53	31	34	-1.9	1.09	0.4	0.3	0	52.5	53.8	0	149	152	0	27	27
2025	10	7	7	3	31	34	-1.7	1.09	0.3	0.2	0	52.5	53.8	0	149	152	0	27	27
2025	10	7	7	13	31	33.5	-0.9	1.09	0.5	0.4	0	52.5	53.8	0	149	152	0	27	27
2025	10	7	7	23	31	34.1	-2	1.09	0.3	0.2	0	52.5	52.9	0	149	151	0	27	28
2025	10	7	7	33	31	33.5	-1.7	1.09	0.5	0.4	0	52	53.3	0	148	151	0	27	27
2025	10	7	7	43	31	33.5	0	1.09	0.5	0.5	0	52	52.9	0	149	151	0	28	28
2025	10	7	7	53	31	33.3	-0.7	1.09	0.4	0.3	0	52	53.3	0	148	151	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	7	8	3	31	33.3	-2.5	1.09	0.3	0.2	0	52	52.9	0	148	151	0	27	28
2025	10	7	8	13	31	34.1	-1.3	1.09	0.5	0.4	0	52.5	53.3	0	149	151	0	27	27
2025	10	7	8	23	31	33.6	-1.5	1.09	0.4	0.3	0	52.5	53.3	0	148	151	0	26	27
2025	10	7	8	33	31	34.2	-1.9	1.09	0.3	0.2	0	52	52.9	0	148	150	0	27	27
2025	10	7	8	43	31	34.9	-0.7	1.09	0.4	0.3	0	52	52.9	0	147	150	0	26	27
2025	10	7	8	53	31	33.5	-1.7	1.09	0.5	0.4	0	51.6	52.5	0	147	149	0	27	27
2025	10	7	9	3	31	33.5	-2	1.09	0.5	0.4	0	51.2	52	0	146	148	0	27	27
2025	10	7	9	13	31	34.7	-2.1	1.09	0.5	0.4	0	51.2	51.6	0	146	148	0	27	28
2025	10	7	9	23	31	33.8	-1.3	1.09	0.5	0.4	0	50.7	52	0	145	148	0	27	27
2025	10	7	9	33	31	34.5	-2	1.09	0.5	0.5	0	50.7	51.2	0	145	147	0	27	28
2025	10	7	9	43	31	34.2	-2.4	1.09	0.4	0.3	0	50.7	51.6	0	145	147	0	27	27
2025	10	7	9	53	31	33.8	-1.3	1.09	0.4	0.3	0	50.7	51.6	0	145	147	0	27	27
2025	10	7	10	3	31	34.2	-1.1	1.09	0.5	0.4	0	50.7	51.6	0	144	147	0	26	27
2025	10	7	10	13	31	34	-1.7	1.09	0.5	0.4	0	50.3	51.2	0	144	147	0	27	28
2025	10	7	10	23	31	34.8	-2.8	1.09	0.4	0.3	0	50.7	52	0	145	147	0	27	26
2025	10	7	10	33	31	33.9	-1.9	1.09	0.5	0.4	0	50.7	51.6	0	145	147	0	27	27
2025	10	7	10	43	31	33.5	-1	1.09	0.3	0.2	0	50.7	51.6	0	145	147	0	27	27
2025	10	7	10	53	31	33.7	-1.7	1.091	0.4	0.3	0	51.2	52	0	145	147	0	26	26
2025	10	7	11	3	31	34.3	-2	1.09	0.3	0.2	0	50.3	51.2	0	144	146	0	27	27
2025	10	7	11	13	31	34.1	-1.7	1.091	0.3	0.2	0	50.3	51.6	0	144	147	0	27	27
2025	10	7	11	23	31	34	-1.7	1.091	0.4	0.3	0	49.9	51.2	0	143	146	0	27	27
2025	10	7	11	33	31	33.8	-1	1.091	0.5	0.4	0	50.3	51.2	0	144	147	0	27	28
2025	10	7	11	43	31	33.8	-1.8	1.091	0.4	0.3	0	49.9	51.2	0	143	146	0	27	27
2025	10	7	11	53	31	33.7	-1.6	1.091	0.5	0.4	0	50.3	51.6	0	144	146	0	27	26
2025	10	7	12	3	31	33.9	-1.6	1.091	0.5	0.5	0	50.3	51.2	0	143	146	0	26	27
2025	10	7	12	13	31	34.1	-1.2	1.091	0.4	0.3	0	49.9	51.2	0	143	145	0	27	26
2025	10	7	12	23	31	35	-2.3	1.091	0.4	0.3	0	49.5	50.7	0	142	145	0	27	27
2025	10	7	12	33	31	33.8	-2.6	1.091	0.3	0.2	0	49.5	50.7	0	142	145	0	27	27
2025	10	7	12	43	31	34.4	-1.6	1.091	0.5	0.4	0	49.5	50.7	0	142	145	0	27	27
2025	10	7	12	53	31	33.4	-1.3	1.091	0.4	0.3	0	49.9	50.7	0	142	145	0	26	27
2025	10	7	13	3	31	34.3	-1.1	1.091	0.4	0.3	0	49.9	50.7	0	142	145	0	26	27
2025	10	7	13	13	31	34.7	-2	1.091	0.3	0.2	0	49.5	50.3	0	141	144	0	26	27
2025	10	7	13	23	31	35.2	-2.4	1.091	0.3	0.2	0	49	50.3	0	141	144	0	27	27
2025	10	7	13	33	31	32.7	-0.9	1.091	0.5	0.4	0	49	50.3	0	141	144	0	27	27
2025	10	7	13	43	31	34.5	-2.3	1.091	0.4	0.3	0	49	50.3	0	141	144	0	27	27
2025	10	7	13	53	31	34	-1.3	1.091	0.3	0.2	0	49.5	50.7	0	142	145	0	27	27
2025	10	7	14	3	31	33.1	-2.9	1.091	0.4	0.3	0	49	50.3	0	141	144	0	27	27
2025	10	7	14	13	31	34.3	-1.4	1.091	0.4	0.3	0	49.5	50.7	0	142	145	0	27	27
2025	10	7	14	23	31	33.8	-2.6	1.091	0.3	0.2	0	49.5	50.7	0	142	145	0	27	27
2025	10	7	14	33	31	35.4	-1.3	1.092	0.4	0.3	0	49	50.7	0	141	144	0	27	26
2025	10	7	14	43	31	34.2	-1.5	1.091	0.5	0.5	0	49	50.3	0	141	144	0	27	27
2025	10	7	14	53	31	34.1	-1.2	1.091	0.5	0.4	0	49.5	50.7	0	142	145	0	27	27
2025	10	7	15	3	31	33.9	-2	1.091	0.4	0.3	0	49.5	50.7	0	142	145	0	27	27
2025	10	7	15	13	31	33	-1.6	1.092	0.5	0.4	0	49	50.7	0	141	145	0	27	27
2025	10	7	15	23	31	33.3	-2.4	1.091	0.4	0.3	0	49	51.2	0	141	145	0	27	26
2025	10	7	15	33	31	33.5	-0.4	1.091	0.5	0.4	0	49.5	51.6	0	142	146	0	27	26
2025	10	7	15	43	31	33.9	-1.5	1.091	0.4	0.3	0	49	50.7	0	141	145	0	27	27
2025	10	7	15	53	31	34.5	-0.8	1.091	0.4	0.3	0	49.5	51.6	0	142	146	0	27	26

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	7	16	3	31	33.5	-1.3	1.091	0.5	0.4	0	49	50.7	0	141	145	0	27	27
2025	10	7	16	13	31	34.7	-1.6	1.091	0.5	0.4	0	49	50.3	0	140	144	0	26	27
2025	10	7	16	23	31	34.3	-1.6	1.091	0.5	0.5	0	48.6	50.3	0	140	144	0	27	27
2025	10	7	16	33	31	34.4	-1.8	1.091	0.5	0.4	0	49.5	50.7	0	141	145	0	26	27
2025	10	7	16	43	31	33.8	-0.9	1.091	0.5	0.4	0	49	50.7	0	141	145	0	27	27
2025	10	7	16	53	31	34	-1.3	1.091	0.3	0.2	0	49	50.3	0	141	144	0	27	27
2025	10	7	17	3	31	34.9	-1.7	1.091	0.3	0.2	0	49.5	51.2	0	141	145	0	26	26
2025	10	7	17	13	31	34.7	-2.1	1.091	0.5	0.4	0	48.6	50.3	0	140	144	0	27	27
2025	10	7	17	23	31	34.2	-1.4	1.091	0.3	0.2	0	49	50.3	0	141	145	0	27	28
2025	10	7	17	33	31	33.2	-1.3	1.091	0.4	0.3	0	48.6	50.3	0	140	144	0	27	27
2025	10	7	17	43	31	33.2	-1.7	1.091	0.4	0.3	0	48.6	50.3	0	140	144	0	27	27
2025	10	7	17	53	31	34	-1.3	1.091	0.4	0.3	0	48.2	50.3	0	139	144	0	27	27
2025	10	7	18	3	31	35.1	-1.8	1.091	0.3	0.2	0	48.6	50.3	0	140	144	0	27	27
2025	10	7	18	13	31	35.2	-1.6	1.091	0.4	0.3	0	48.6	49.9	0	139	143	0	26	27
2025	10	7	18	23	31	33.4	-0.8	1.091	0.4	0.3	0	48.6	51.2	0	140	145	0	27	26
2025	10	7	18	33	31	33.4	-0.7	1.091	0.5	0.4	0	48.6	50.7	0	140	145	0	27	27
2025	10	7	18	43	31	34.6	-1.7	1.091	0.5	0.4	0	49.5	51.2	0	141	145	0	26	26
2025	10	7	18	53	31	33.8	-1.5	1.091	0.3	0.2	0	49	51.2	0	141	146	0	27	27
2025	10	7	19	3	31	34.6	-1.3	1.091	0.4	0.3	0	49	51.2	0	141	145	0	27	26
2025	10	7	19	13	31	34	-1.4	1.091	0.4	0.3	0	49.9	51.2	0	142	146	0	26	27
2025	10	7	19	23	31	33.8	-0.7	1.091	0.3	0.2	0	49.5	51.6	0	142	146	0	27	26
2025	10	7	19	33	31	34.4	-1	1.091	0.4	0.3	0	49.9	52	0	142	147	0	26	26
2025	10	7	19	43	31	34.4	-1	1.091	0.3	0.2	0	49.5	51.6	0	142	147	0	27	27
2025	10	7	19	53	31	33.7	-1.3	1.091	0.4	0.3	0	50.3	52	0	143	148	0	26	27
2025	10	7	20	3	31	34.9	-2.2	1.091	0.4	0.3	0	49.9	51.6	0	142	147	0	26	27
2025	10	7	20	13	31	34	-0.6	1.091	0.5	0.5	0	49.9	52	0	143	148	0	27	27
2025	10	7	20	23	31	35	-1.6	1.091	0.4	0.3	0	50.3	51.6	0	143	147	0	26	27
2025	10	7	20	33	31	34.4	-1.3	1.091	0.5	0.5	0	49.9	52	0	143	148	0	27	27
2025	10	7	20	43	31	34.3	-1.9	1.091	0.4	0.3	0	49.9	52	0	143	148	0	27	27
2025	10	7	20	53	31	33.9	-0.2	1.091	0.5	0.4	0	49.9	52.5	0	143	148	0	27	26
2025	10	7	21	3	31	34.4	-1.9	1.091	0.4	0.3	0	50.3	52	0	143	148	0	26	27
2025	10	7	21	13	31	34.9	-2	1.091	0.4	0.3	0	50.3	52	0	143	148	0	26	27
2025	10	7	21	23	31	33.8	-0.4	1.091	0.3	0.2	0	50.3	52	0	144	148	0	27	27
2025	10	7	21	33	31	33.5	-0.9	1.09	0.5	0.5	0	50.7	52.5	0	144	149	0	26	27
2025	10	7	21	43	31	33.6	-1.7	1.091	0.4	0.3	0	50.7	52	0	144	148	0	26	27
2025	10	7	21	53	31	33.4	-2.1	1.09	0.4	0.3	0	49.9	52	0	143	148	0	27	27
2025	10	7	22	3	31	34.6	-1.7	1.09	0.4	0.3	0	50.7	52.5	0	144	149	0	26	27
2025	10	7	22	13	31	34.9	-1.1	1.09	0.5	0.4	0	49.9	52	0	143	148	0	27	27
2025	10	7	22	23	31	33.3	-1.9	1.09	0.5	0.4	0	50.3	52	0	144	149	0	27	28
2025	10	7	22	33	31	34	-2.1	1.09	0.4	0.3	0	49.9	52.5	0	143	149	0	27	27
2025	10	7	22	43	31	34.7	-1.2	1.09	0.4	0.3	0	50.3	52.5	0	144	149	0	27	27
2025	10	7	22	53	31	34.4	-1.6	1.09	0.3	0.2	0	50.3	52.5	0	144	149	0	27	27
2025	10	7	23	3	31	33.4	-1.4	1.09	0.3	0.2	0	50.3	52.5	0	144	149	0	27	27
2025	10	7	23	13	31	33.6	-1.9	1.09	0.4	0.3	0	50.3	52.5	0	144	149	0	27	27
2025	10	7	23	23	31	34.3	-2.4	1.09	0.5	0.4	0	49.9	52	0	143	148	0	27	27
2025	10	7	23	33	31	34.7	-0.8	1.09	0.3	0.2	0	50.3	52.5	0	144	149	0	27	27
2025	10	7	23	43	31	34.1	-1.2	1.09	0.5	0.4	0	50.3	52.5	0	144	149	0	27	27
2025	10	7	23	53	31	34.4	-1.3	1.09	0.4	0.3	0	50.3	52.5	0	144	149	0	27	27

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	8	0	3	31	33.2	-0.8	1.09	0.5	0.5	0	50.3	52.5	0	144	149	0	27	27
2025	10	8	0	13	31	34.8	-1.7	1.09	0.4	0.3	0	50.7	52	0	144	149	0	26	28
2025	10	8	0	23	31	33.7	-1	1.09	0.4	0.3	0	50.3	52.5	0	144	149	0	27	27
2025	10	8	0	33	31	34.1	-1.9	1.09	0.5	0.4	0	50.3	52.5	0	144	149	0	27	27
2025	10	8	0	43	31	33	-2	1.09	0.4	0.3	0	50.3	52.5	0	144	149	0	27	27
2025	10	8	0	53	31	34.3	-1.2	1.09	0.5	0.4	0	50.3	52.5	0	144	149	0	27	27
2025	10	8	1	3	31	34.4	-1.9	1.09	0.4	0.3	0	50.3	52.5	0	144	149	0	27	27
2025	10	8	1	13	31	34.7	-1.2	1.09	0.4	0.3	0	50.3	52.9	0	144	149	0	27	26
2025	10	8	1	23	31	34.2	-1.2	1.09	0.4	0.3	0	50.3	52.5	0	144	149	0	27	27
2025	10	8	1	33	31	33.6	-1.3	1.09	0.5	0.4	0	50.3	52.9	0	144	150	0	27	27
2025	10	8	1	43	31	34.5	-1.8	1.09	0.4	0.3	0	50.3	52.9	0	144	150	0	27	27
2025	10	8	1	53	31	34.5	-1.3	1.09	0.3	0.2	0	50.3	52.5	0	144	150	0	27	28
2025	10	8	2	3	31	34.1	-2	1.09	0.5	0.4	0	50.3	52.5	0	144	149	0	27	27
2025	10	8	2	13	31	34.5	-1.7	1.09	0.4	0.3	0	50.7	52.9	0	145	150	0	27	27
2025	10	8	2	23	31	34.2	-0.6	1.09	0.5	0.4	0	50.3	52.9	0	144	150	0	27	27
2025	10	8	2	33	31	33.4	-1.9	1.09	0.5	0.4	0	50.7	52.9	0	145	150	0	27	27
2025	10	8	2	43	31	34.1	-1.6	1.09	0.4	0.3	0	50.7	52.5	0	145	150	0	27	28
2025	10	8	2	53	31	33.4	-1.6	1.09	0.3	0.2	0	50.3	52.5	0	144	150	0	27	28
2025	10	8	3	3	31	33.9	-1.6	1.09	0.5	0.4	0	50.7	52.9	0	145	150	0	27	27
2025	10	8	3	13	31	33.9	-2.5	1.09	0.5	0.4	0	50.3	52.9	0	144	150	0	27	27
2025	10	8	3	23	31	33.8	-1.8	1.09	0.5	0.4	0	50.7	52.9	0	144	150	0	26	27
2025	10	8	3	33	31	33.4	-0.9	1.09	0.4	0.3	0	50.7	53.3	0	145	150	0	27	26
2025	10	8	3	43	31	34.2	-1.1	1.09	0.5	0.4	0	50.7	52.9	0	144	150	0	26	27
2025	10	8	3	53	31	34.7	-0.3	1.089	0.4	0.3	0	50.7	52.9	0	145	150	0	27	27
2025	10	8	4	3	31	34	-1.7	1.09	0.4	0.3	0	50.7	52.9	0	145	150	0	27	27
2025	10	8	4	13	31	34.6	-0.4	1.09	0.4	0.3	0	50.7	52.5	0	145	150	0	27	28
2025	10	8	4	23	31	33.6	-0.2	1.09	0.3	0.2	0	50.7	52.9	0	145	150	0	27	27
2025	10	8	4	33	31	34.7	-2.3	1.09	0.3	0.2	0	52	52.9	0	147	150	0	26	27
2025	10	8	4	43	31	32.7	-2.1	1.09	0.3	0.2	0	52	52.9	0	148	150	0	27	27
2025	10	8	4	53	31	34.4	-0.8	1.09	0.4	0.3	0	52	52.9	0	148	150	0	27	27
2025	10	8	5	3	31	33.9	-1.2	1.09	0.4	0.3	0	52	52.9	0	148	150	0	27	27
2025	10	8	5	13	31	34.8	-0.4	1.09	0.4	0.3	0	52	53.3	0	148	151	0	27	27
2025	10	8	5	23	31	33	-2.1	1.09	0.3	0.2	0	52.5	52.5	0	148	150	0	26	28
2025	10	8	5	33	31	34.3	-0.9	1.09	0.4	0.3	0	52	52.9	0	148	151	0	27	28
2025	10	8	5	43	31	33.4	-1.7	1.09	0.3	0.2	0	52.5	52.9	0	148	150	0	26	27
2025	10	8	5	53	31	34	-0.8	1.09	0.4	0.3	0	52	53.3	0	148	151	0	27	27
2025	10	8	6	3	31	34.6	-2	1.09	0.5	0.5	0	51.6	52.9	0	147	150	0	27	27
2025	10	8	6	13	31	34.6	-2.6	1.09	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	8	6	23	31	33.1	-1.2	1.09	0.5	0.4	0	52	53.3	0	148	151	0	27	27
2025	10	8	6	33	31	33.8	-1	1.09	0.4	0.3	0	52	53.3	0	148	151	0	27	27
2025	10	8	6	43	31	34.1	-1.6	1.09	0.4	0.3	0	52	53.3	0	148	151	0	27	27
2025	10	8	6	53	31	34	-1.6	1.09	0.4	0.3	0	52	53.3	0	148	151	0	27	27
2025	10	8	7	3	31	34	-1.2	1.09	0.4	0.3	0	52	53.3	0	148	151	0	27	27
2025	10	8	7	13	31	33.7	-0.3	1.09	0.5	0.4	0	52	53.3	0	149	151	0	28	27
2025	10	8	7	23	31	33.5	-1.1	1.09	0.4	0.3	0	52	52.9	0	148	150	0	27	27
2025	10	8	7	33	31	33.7	-1.3	1.09	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	8	7	43	31	33.4	-1.2	1.09	0.3	0.2	0	52	52.5	0	148	150	0	27	28
2025	10	8	7	53	31	32.6	-1.3	1.09	0.3	0.2	0	51.6	52.9	0	148	150	0	28	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	8	8	3	31	34.5	-1.8	1.09	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	8	8	13	31	33.6	-1	1.09	0.4	0.3	0	51.6	52.5	0	147	149	0	27	27
2025	10	8	8	23	31	34.4	-1.6	1.09	0.4	0.3	0	51.6	52	0	147	149	0	27	28
2025	10	8	8	33	31	33.3	-1.8	1.091	0.5	0.4	0	51.2	52.5	0	146	149	0	27	27
2025	10	8	8	43	31	34.5	-1.2	1.09	0.4	0.3	0	51.2	52.5	0	146	149	0	27	27
2025	10	8	8	53	31	33.5	-0.1	1.09	0.3	0.2	0	50.7	52	0	146	148	0	28	27
2025	10	8	9	3	31	33.2	-2.1	1.09	0.3	0.2	0	51.2	52	0	146	148	0	27	27
2025	10	8	9	13	31	33.4	-0.7	1.09	0.3	0.2	0	51.6	52	0	146	148	0	26	27
2025	10	8	9	23	31	33.7	-1.1	1.091	0.5	0.4	0	50.7	51.6	0	145	147	0	27	27
2025	10	8	9	33	31	33.9	-2	1.09	0.4	0.3	0	50.7	51.6	0	145	147	0	27	27
2025	10	8	9	43	31	33.6	-2	1.091	0.4	0.3	0	50.3	51.6	0	144	147	0	27	27
2025	10	8	9	53	31	34.4	-1.3	1.091	0.4	0.3	0	51.2	52	0	146	148	0	27	27
2025	10	8	10	3	31	33.9	-2.3	1.091	0.5	0.4	0	50.7	52	0	145	148	0	27	27
2025	10	8	10	13	31	34.5	-1.1	1.091	0.5	0.4	0	50.3	51.6	0	144	147	0	27	27
2025	10	8	10	23	31	33.4	-1.7	1.091	0.3	0.2	0	50.3	51.6	0	144	147	0	27	27
2025	10	8	10	33	31	34.2	-1.2	1.091	0.4	0.3	0	50.3	51.2	0	144	146	0	27	27
2025	10	8	10	43	31	32.9	-1.8	1.091	0.5	0.4	0	50.3	51.2	0	144	146	0	27	27
2025	10	8	10	53	31	33.9	-1.8	1.091	0.4	0.3	0	49.9	50.7	0	143	146	0	27	28
2025	10	8	11	3	31	34.5	-2.2	1.091	0.4	0.3	0	50.3	51.2	0	144	146	0	27	27
2025	10	8	11	13	31	35.6	-1.2	1.091	0.5	0.5	0	50.3	51.2	0	143	146	0	26	27
2025	10	8	11	23	31	33.9	-2.3	1.091	0.3	0.2	0	49.9	50.7	0	143	145	0	27	27
2025	10	8	11	33	31	34.2	-2.8	1.091	0.3	0.2	0	49.5	50.7	0	142	145	0	27	27
2025	10	8	11	43	31	34.3	-2.1	1.091	0.5	0.4	0	50.3	50.3	0	143	145	0	26	28
2025	10	8	11	53	31	34	-2.3	1.091	0.5	0.4	0	49.5	50.7	0	142	145	0	27	27
2025	10	8	12	3	31	33.9	-1.6	1.091	0.4	0.3	0	49.5	50.3	0	142	145	0	27	28
2025	10	8	12	13	31	34	-2.1	1.091	0.4	0.3	0	49.5	50.7	0	142	145	0	27	27
2025	10	8	12	23	31	33.6	-2.2	1.091	0.5	0.4	0	49.5	50.7	0	142	145	0	27	27
2025	10	8	12	33	31	33.8	-0.8	1.091	0.4	0.3	0	49.9	50.7	0	143	145	0	27	27
2025	10	8	12	43	31	34	-1.5	1.091	0.4	0.3	0	49.9	50.7	0	143	146	0	27	28
2025	10	8	12	53	31	33.7	-1.4	1.091	0.4	0.3	0	49.9	50.7	0	143	146	0	27	28
2025	10	8	13	3	31	33.6	-1.4	1.092	0.4	0.3	0	49.5	51.2	0	142	146	0	27	27
2025	10	8	13	13	31	33.4	-2.1	1.092	0.3	0.2	0	49.9	50.7	0	143	145	0	27	27
2025	10	8	13	23	31	34	-1.8	1.093	0.4	0.3	0	50.3	51.2	0	143	146	0	26	27
2025	10	8	13	33	31	33.7	-0.7	1.092	0.5	0.4	0	50.3	51.6	0	144	147	0	27	27
2025	10	8	13	43	31	34.2	-1.7	1.092	0.4	0.3	0	50.7	52	0	145	148	0	27	27
2025	10	8	13	53	31	33	-2.1	1.092	0.3	0.2	0	50.3	52	0	145	148	0	28	27
2025	10	8	14	3	31	33.4	-1.9	1.091	0.3	0.2	0	51.2	52	0	146	149	0	27	28
2025	10	8	14	13	31	34	-1	1.091	0.5	0.4	0	52	52.9	0	148	150	0	27	27
2025	10	8	14	23	31	33.1	-2.1	1.091	0.4	0.3	0	52	52.9	0	147	150	0	26	27
2025	10	8	14	33	31	33.8	-0.9	1.091	0.3	0.2	0	52	53.3	0	148	151	0	27	27
2025	10	8	14	43	31	33.7	-2.5	1.092	0.4	0.3	0	52	53.3	0	148	151	0	27	27
2025	10	8	14	53	31	34.3	-1.8	1.092	0.5	0.4	0	52.5	53.8	0	149	152	0	27	27
2025	10	8	15	3	31	34.3	-2.3	1.091	0.5	0.4	0	52.5	53.8	0	149	152	0	27	27
2025	10	8	15	13	31	34.2	-1.2	1.091	0.5	0.4	0	52.5	54.2	0	149	152	0	27	26
2025	10	8	15	23	31	33.9	-0.2	1.092	0.5	0.4	0	52.9	54.2	0	150	153	0	27	27
2025	10	8	15	33	31	33.7	-2.3	1.091	0.5	0.5	0	52.9	54.2	0	150	153	0	27	27
2025	10	8	15	43	31	33.9	-1.8	1.091	0.3	0.2	0	52.9	54.2	0	150	153	0	27	27
2025	10	8	15	53	31	34.1	-2.1	1.091	0.4	0.3	0	53.3	54.6	0	151	154	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	8	16	3	31	33.6	-1.7	1.09	0.3	0.2	0	53.8	55	0	152	155	0	27	27
2025	10	8	16	13	31	33.9	-0.8	1.09	0.3	0.2	0	53.3	55	0	151	155	0	27	27
2025	10	8	16	23	31	33.9	-1.7	1.091	0.5	0.4	0	52.9	54.2	0	150	153	0	27	27
2025	10	8	16	33	31	33.5	-1.4	1.09	0.4	0.3	0	53.3	55.5	0	151	155	0	27	26
2025	10	8	16	43	31	34.4	-0.8	1.091	0.5	0.4	0	53.3	55	0	151	155	0	27	27
2025	10	8	16	53	31	32.9	-1.7	1.09	0.4	0.3	0	53.8	55	0	152	155	0	27	27
2025	10	8	17	3	31	33.1	-1.7	1.09	0.4	0.3	0	53.8	55	0	151	155	0	26	27
2025	10	8	17	13	31	33.6	-2.1	1.09	0.5	0.4	0	53.3	54.6	0	151	154	0	27	27
2025	10	8	17	23	31	33.2	-1.5	1.089	0.4	0.3	0	53.3	55	0	151	155	0	27	27
2025	10	8	17	33	31	33.7	-2	1.09	0.5	0.4	0	52.9	54.6	0	150	154	0	27	27
2025	10	8	17	43	31	33.9	-1.6	1.09	0.3	0.2	0	53.3	54.6	0	150	154	0	26	27
2025	10	8	17	53	31	34.2	-2.8	1.09	0.4	0.3	0	52.5	54.6	0	149	153	0	27	26
2025	10	8	18	3	31	33.6	-1.7	1.089	0.3	0.2	0	52	54.2	0	149	153	0	28	27
2025	10	8	18	13	31	34	-1.7	1.09	0.5	0.4	0	52.5	53.8	0	148	152	0	26	27
2025	10	8	18	23	31	33.8	-1.6	1.09	0.4	0.3	0	52.9	54.6	0	149	153	0	26	26
2025	10	8	18	33	31	33.2	-2.1	1.09	0.3	0.2	0	52.9	54.2	0	149	153	0	26	27
2025	10	8	18	43	31	34.2	-2	1.089	0.3	0.2	0	52.5	54.2	0	149	153	0	27	27
2025	10	8	18	53	31	34.8	-2.1	1.09	0.4	0.3	0	52.5	54.2	0	149	153	0	27	27
2025	10	8	19	3	31	33.7	-1.3	1.089	0.4	0.3	0	53.3	55	0	151	155	0	27	27
2025	10	8	19	13	31	34.7	-0.6	1.09	0.3	0.2	0	52.9	54.2	0	150	153	0	27	27
2025	10	8	19	23	31	33.9	-1.9	1.089	0.4	0.3	0	52.9	54.2	0	150	154	0	27	28
2025	10	8	19	33	31	33.7	-1.6	1.089	0.3	0.2	0	52	54.6	0	148	153	0	27	26
2025	10	8	19	43	31	34.6	-1.7	1.089	0.5	0.5	0	52.5	54.2	0	149	153	0	27	27
2025	10	8	19	53	31	33.7	-1.6	1.089	0.3	0.2	0	52.5	54.6	0	149	154	0	27	27
2025	10	8	20	3	31	34.9	-1.4	1.09	0.3	0.2	0	52.5	54.2	0	149	153	0	27	27
2025	10	8	20	13	31	34.6	-1.5	1.088	0.5	0.4	0	52.5	54.6	0	149	154	0	27	27
2025	10	8	20	23	31	33.7	-1	1.089	0.4	0.3	0	52.9	55	0	150	155	0	27	27
2025	10	8	20	33	31	34.2	-1.9	1.089	0.4	0.3	0	52.5	54.6	0	149	154	0	27	27
2025	10	8	20	43	31	33.3	-1.5	1.089	0.5	0.4	0	52.9	54.6	0	150	154	0	27	27
2025	10	8	20	53	31	33.9	-1.6	1.089	0.3	0.2	0	52.5	54.2	0	149	153	0	27	27
2025	10	8	21	3	31	33.6	-1.1	1.089	0.5	0.5	0	52.9	54.2	0	149	153	0	26	27
2025	10	8	21	13	31	33.5	-1.7	1.089	0.5	0.4	0	52.5	55	0	149	154	0	27	26
2025	10	8	21	23	31	33.1	-1.9	1.089	0.3	0.2	0	52.9	54.6	0	150	154	0	27	27
2025	10	8	21	33	31	33.2	-1.6	1.09	0.3	0.2	0	52.5	54.2	0	149	153	0	27	27
2025	10	8	21	43	31	33.2	-1	1.088	0.5	0.4	0	52.9	54.6	0	150	154	0	27	27
2025	10	8	21	53	31	33.4	-2.1	1.088	0.3	0.2	0	52.9	54.6	0	150	155	0	27	28
2025	10	8	22	3	31	33.9	-1.9	1.089	0.4	0.3	0	53.3	55	0	151	155	0	27	27
2025	10	8	22	13	31	33.1	-1.5	1.089	0.3	0.2	0	53.3	55	0	151	156	0	27	28
2025	10	8	22	23	31	32.7	-2	1.089	0.4	0.3	0	53.3	54.6	0	151	155	0	27	28
2025	10	8	22	33	31	33.5	-3	1.088	0.5	0.5	0	53.3	55	0	151	155	0	27	27
2025	10	8	22	43	31	34.5	-1.7	1.089	0.5	0.4	0	52.9	54.2	0	150	154	0	27	28
2025	10	8	22	53	31	33.9	-2.4	1.088	0.4	0.3	0	52.9	55	0	150	155	0	27	27
2025	10	8	23	3	31	34.2	-0.8	1.089	0.3	0.2	0	52.9	54.2	0	150	154	0	27	28
2025	10	8	23	13	31	34.4	-2.1	1.089	0.3	0.2	0	52.5	54.6	0	150	154	0	28	27
2025	10	8	23	23	31	34.3	-2.1	1.088	0.4	0.3	0	52.9	54.6	0	149	154	0	26	27
2025	10	8	23	33	31	34.2	-1.9	1.088	0.4	0.3	0	52.5	54.6	0	149	154	0	27	27
2025	10	8	23	43	31	34.3	-2	1.089	0.4	0.3	0	52.9	54.6	0	150	154	0	27	27
2025	10	8	23	53	31	34.7	-1.9	1.088	0.4	0.3	0	52.9	54.6	0	150	154	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	9	0	3	31	34.7	-0.8	1.088	0.4	0.3	0	52.5	54.2	0	149	154	0	27	28
2025	10	9	0	13	31	33.4	-2.9	1.088	0.4	0.3	0	52.5	54.2	0	149	153	0	27	27
2025	10	9	0	23	31	33.4	-1.9	1.088	0.5	0.4	0	52.5	54.6	0	149	154	0	27	27
2025	10	9	0	33	31	34.6	-1.5	1.088	0.4	0.3	0	52.9	54.6	0	150	154	0	27	27
2025	10	9	0	43	31	34.5	-2	1.088	0.5	0.4	0	52.9	54.6	0	150	154	0	27	27
2025	10	9	0	53	31	34	-2.4	1.087	0.4	0.3	0	52.5	54.6	0	150	154	0	28	27
2025	10	9	1	3	31	33.9	-1.9	1.089	0.5	0.5	0	52.9	54.6	0	149	154	0	26	27
2025	10	9	1	13	31	34.3	-1.7	1.088	0.5	0.4	0	52.5	54.6	0	149	154	0	27	27
2025	10	9	1	23	31	33.7	-1.7	1.089	0.5	0.4	0	53.3	54.6	0	150	154	0	26	27
2025	10	9	1	33	31	34.1	-1.3	1.088	0.4	0.3	0	52.5	54.6	0	149	154	0	27	27
2025	10	9	1	43	31	34	-0.8	1.088	0.4	0.3	0	54.6	54.6	0	154	154	0	27	27
2025	10	9	1	53	31	33.1	-2.1	1.089	0.4	0.3	0	55	54.6	0	154	154	0	26	27
2025	10	9	2	3	31	34.1	-1.3	1.089	0.5	0.4	0	54.6	54.6	0	154	154	0	27	27
2025	10	9	2	13	31	34.4	-1.8	1.089	0.3	0.2	0	54.6	55	0	154	154	0	27	26
2025	10	9	2	23	31	34.2	-1.6	1.088	0.4	0.3	0	54.2	54.2	0	153	154	0	27	28
2025	10	9	2	33	31	34.3	-1.5	1.088	0.3	0.2	0	54.2	54.6	0	153	154	0	27	27
2025	10	9	2	43	31	34	-1.1	1.089	0.3	0.2	0	54.6	54.6	0	154	154	0	27	27
2025	10	9	2	53	31	34	-0.9	1.088	0.5	0.4	0	54.6	54.6	0	153	154	0	26	27
2025	10	9	3	3	31	34.5	-1.3	1.088	0.5	0.4	0	54.6	54.6	0	154	154	0	27	27
2025	10	9	3	13	31	34.7	-1.6	1.088	0.3	0.2	0	55	54.6	0	154	154	0	26	27
2025	10	9	3	23	31	33.4	-1.4	1.089	0.3	0.2	0	54.2	54.6	0	153	154	0	27	27
2025	10	9	3	33	31	34	-2.7	1.089	0.5	0.4	0	54.2	54.6	0	153	154	0	27	27
2025	10	9	3	43	31	33.8	-1.7	1.089	0.3	0.2	0	54.2	54.6	0	153	154	0	27	27
2025	10	9	3	53	31	33.8	-1.3	1.088	0.5	0.4	0	54.2	54.6	0	153	154	0	27	27
2025	10	9	4	3	31	35.1	-1.1	1.088	0.4	0.3	0	54.2	54.6	0	153	154	0	27	27
2025	10	9	4	13	31	34.3	-0.9	1.088	0.3	0.2	0	53.8	54.2	0	153	154	0	28	28
2025	10	9	4	23	31	32.7	-1.3	1.088	0.3	0.2	0	54.6	54.2	0	154	154	0	27	28
2025	10	9	4	33	31	33.5	-2.4	1.088	0.5	0.4	0	53.8	54.2	0	153	154	0	28	28
2025	10	9	4	43	31	34.6	-1	1.088	0.4	0.3	0	54.6	54.6	0	153	154	0	26	27
2025	10	9	4	53	31	33.3	-1.3	1.088	0.5	0.4	0	54.2	54.2	0	153	154	0	27	28
2025	10	9	5	3	31	32.5	-1.8	1.089	0.5	0.4	0	53.8	54.6	0	152	154	0	27	27
2025	10	9	5	13	31	33.7	-1.9	1.089	0.5	0.4	0	53.8	54.2	0	152	153	0	27	27
2025	10	9	5	23	31	33.6	-1.6	1.089	0.4	0.3	0	54.6	54.6	0	153	154	0	26	27
2025	10	9	5	33	31	34.2	-2.2	1.089	0.4	0.3	0	53.8	54.6	0	153	154	0	28	27
2025	10	9	5	43	31	33.2	-1.9	1.089	0.4	0.3	0	53.8	54.6	0	153	154	0	28	27
2025	10	9	5	53	31	34.4	-1.3	1.089	0.5	0.4	0	53.8	54.2	0	152	153	0	27	27
2025	10	9	6	3	31	33.3	-1.5	1.089	0.5	0.4	0	53.8	53.8	0	152	153	0	27	28
2025	10	9	6	13	31	33.7	-1.7	1.088	0.5	0.4	0	53.8	54.2	0	152	153	0	27	27
2025	10	9	6	23	31	34.1	-1.2	1.089	0.5	0.5	0	54.2	54.6	0	153	155	0	27	28
2025	10	9	6	33	31	33.1	-2.8	1.089	0.5	0.4	0	54.6	55	0	153	155	0	26	27
2025	10	9	6	43	31	34.1	-1.3	1.089	0.3	0.2	0	54.2	54.2	0	153	154	0	27	28
2025	10	9	6	53	31	33.6	-1.5	1.089	0.3	0.2	0	54.2	54.6	0	153	154	0	27	27
2025	10	9	7	3	31	34.2	-1.6	1.088	0.4	0.3	0	54.2	55	0	153	155	0	27	27
2025	10	9	7	13	31	34.3	-2.1	1.089	0.4	0.3	0	54.6	54.6	0	153	154	0	26	27
2025	10	9	7	23	31	33.8	-1.6	1.089	0.4	0.3	0	54.2	54.6	0	153	154	0	27	27
2025	10	9	7	33	31	34.1	-1.8	1.089	0.5	0.4	0	54.2	54.2	0	153	154	0	27	28
2025	10	9	7	43	31	34.8	-2	1.089	0.3	0.2	0	54.2	54.2	0	153	154	0	27	28
2025	10	9	7	53	31	34.2	-1.5	1.089	0.5	0.4	0	53.8	54.6	0	152	154	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	9	8	3	31	33.9	-1.3	1.089	0.4	0.3	0	53.8	54.2	0	152	154	0	27	28
2025	10	9	8	13	31	32.8	-1.8	1.089	0.5	0.4	0	53.8	54.6	0	152	154	0	27	27
2025	10	9	8	23	31	33.6	-1.8	1.089	0.4	0.3	0	53.8	54.6	0	152	154	0	27	27
2025	10	9	8	33	31	32.7	-1.9	1.089	0.4	0.3	0	53.3	54.2	0	151	153	0	27	27
2025	10	9	8	43	31	34.1	-1.5	1.089	0.4	0.3	0	53.3	54.2	0	151	153	0	27	27
2025	10	9	8	53	31	33.7	-1.8	1.089	0.3	0.2	0	52.9	53.8	0	150	152	0	27	27
2025	10	9	9	3	31	33.8	-1.7	1.089	0.5	0.5	0	52.9	53.8	0	150	152	0	27	27
2025	10	9	9	13	31	34.1	-2.1	1.089	0.5	0.4	0	53.3	53.8	0	151	153	0	27	28
2025	10	9	9	23	31	33.4	-1.8	1.089	0.3	0.2	0	53.8	54.6	0	152	154	0	27	27
2025	10	9	9	33	31	33	-1.9	1.089	0.5	0.4	0	54.2	54.6	0	152	154	0	26	27
2025	10	9	9	43	31	33.7	-1.6	1.089	0.5	0.5	0	53.8	55	0	152	154	0	27	26
2025	10	9	9	53	31	33.8	-1.1	1.089	0.4	0.3	0	53.3	53.8	0	150	152	0	26	27
2025	10	9	10	3	31	33.1	-2.1	1.089	0.4	0.3	0	52.5	53.3	0	149	152	0	27	28
2025	10	9	10	13	31	33.7	-2.8	1.089	0.4	0.3	0	52.5	52.9	0	149	151	0	27	28
2025	10	9	10	23	31	33	-1.7	1.088	0.5	0.4	0	53.3	54.2	0	151	153	0	27	27
2025	10	9	10	33	31	33	-2.4	1.088	0.5	0.4	0	53.3	53.8	0	151	153	0	27	28
2025	10	9	10	43	31	33.6	-1	1.088	0.3	0.2	0	53.3	53.8	0	151	153	0	27	28
2025	10	9	10	53	31	34.1	-1.5	1.088	0.5	0.4	0	53.3	54.2	0	151	153	0	27	27
2025	10	9	11	3	31	34.1	-2.1	1.087	0.3	0.2	0	53.8	54.2	0	151	153	0	26	27
2025	10	9	11	13	31	34.3	-1.7	1.088	0.3	0.2	0	53.3	53.8	0	150	152	0	26	27
2025	10	9	11	23	31	33.3	-2	1.088	0.5	0.4	0	53.3	54.2	0	151	153	0	27	27
2025	10	9	11	33	31	33.5	-1.9	1.087	0.4	0.3	0	53.3	54.2	0	150	153	0	26	27
2025	10	9	11	43	31	33.6	-1.6	1.087	0.5	0.5	0	53.8	54.2	0	151	153	0	26	27
2025	10	9	11	53	31	32.7	-2.3	1.087	0.5	0.4	0	53.8	53.8	0	151	153	0	26	28
2025	10	9	12	3	31	34	-1.3	1.087	0.4	0.3	0	53.8	54.6	0	152	154	0	27	27
2025	10	9	12	13	31	34.9	-1.6	1.086	0.4	0.3	0	53.3	54.6	0	151	154	0	27	27
2025	10	9	12	23	31	33.5	-1.8	1.086	0.4	0.3	0	53.8	54.2	0	152	154	0	27	28
2025	10	9	12	33	31	32.5	-2.1	1.085	0.5	0.4	0	53.3	54.6	0	152	154	0	28	27
2025	10	9	12	43	31	33.2	-2.2	1.086	0.4	0.3	0	53.3	54.6	0	151	154	0	27	27
2025	10	9	12	53	31	34	-1.8	1.086	0.4	0.3	0	54.2	55	0	152	155	0	26	27
2025	10	9	13	3	31	33.6	-2.5	1.086	0.4	0.3	0	53.3	54.6	0	151	155	0	27	28
2025	10	9	13	13	31	33.6	-0.9	1.085	0.5	0.4	0	53.8	54.6	0	152	155	0	27	28
2025	10	9	13	23	31	34.1	-1.8	1.085	0.3	0.2	0	53.8	54.6	0	152	155	0	27	28
2025	10	9	13	33	31	33.7	-1.6	1.085	0.5	0.5	0	54.2	55	0	152	155	0	26	27
2025	10	9	13	43	31	33	-0.7	1.085	0.3	0.2	0	53.8	55	0	152	155	0	27	27
2025	10	9	13	53	31	34.3	-1.8	1.085	0.3	0.2	0	53.3	55	0	151	155	0	27	27
2025	10	9	14	3	31	33.4	-2.4	1.084	0.4	0.3	0	53.3	55	0	151	155	0	27	27
2025	10	9	14	13	31	33.9	-1.9	1.084	0.5	0.4	0	53.8	54.6	0	151	155	0	26	28
2025	10	9	14	23	31	33.8	-1.1	1.084	0.4	0.3	0	53.3	55	0	151	155	0	27	27
2025	10	9	14	33	31	33.5	-1.9	1.083	0.3	0.2	0	53.8	55	0	152	155	0	27	27
2025	10	9	14	43	31	33.3	-2.4	1.082	0.4	0.3	0	53.8	55	0	152	155	0	27	27
2025	10	9	14	53	31	34.2	-2.3	1.082	0.4	0.3	0	53.3	55.5	0	151	155	0	27	26
2025	10	9	15	3	31	33.2	-1.2	1.082	0.5	0.4	0	53.8	55.5	0	152	156	0	27	27
2025	10	9	15	13	31	33.5	-2.3	1.082	0.5	0.4	0	53.8	55	0	152	155	0	27	27
2025	10	9	15	23	31	33.9	-1.3	1.082	0.5	0.5	0	53.8	55	0	152	156	0	27	28
2025	10	9	15	33	31	33.7	-1.6	1.081	0.4	0.3	0	53.8	55	0	152	156	0	27	28
2025	10	9	15	43	31	33.2	-2.1	1.08	0.3	0.2	0	54.2	55.5	0	152	156	0	26	27
2025	10	9	15	53	31	32.4	-1.7	1.08	0.4	0.3	0	53.8	55	0	152	156	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	9	16	3	31	33.8	-1.6	1.08	0.3	0.2	0	54.6	55.9	0	153	157	0	26	27
2025	10	9	16	13	31	32.6	-1.3	1.08	0.5	0.4	0	53.8	55.5	0	152	156	0	27	27
2025	10	9	16	23	31	32.3	-2.2	1.079	0.5	0.4	0	53.8	55	0	151	155	0	26	27
2025	10	9	16	33	31	33.6	-2	1.079	0.5	0.4	0	52.9	55	0	150	155	0	27	27
2025	10	9	16	43	31	32.8	-2.1	1.079	0.4	0.3	0	52.9	55	0	150	154	0	27	26
2025	10	9	16	53	31	33.2	-1.3	1.078	0.4	0.3	0	52.9	55	0	150	155	0	27	27
2025	10	9	17	3	31	34	-1.8	1.077	0.4	0.3	0	52.9	55	0	150	155	0	27	27
2025	10	9	17	13	31	33.2	-1.4	1.077	0.4	0.3	0	52.9	55	0	150	155	0	27	27
2025	10	9	17	23	31	32.5	-1.7	1.076	0.4	0.3	0	53.3	54.6	0	150	154	0	26	27
2025	10	9	17	33	31	32.8	-0.8	1.076	0.5	0.4	0	52.9	54.2	0	150	154	0	27	28
2025	10	9	17	43	31	33.8	-1.4	1.076	0.5	0.4	0	52.5	54.2	0	149	153	0	27	27
2025	10	9	17	53	31	33.6	-2.1	1.075	0.5	0.4	0	52	54.2	0	148	153	0	27	27
2025	10	9	18	3	31	33	-2.1	1.075	0.4	0.3	0	54.2	54.2	0	153	153	0	27	27
2025	10	9	18	13	31	33.4	-1.5	1.074	0.3	0.2	0	53.8	53.8	0	152	153	0	27	28
2025	10	9	18	23	31	32.6	-2.1	1.073	0.5	0.5	0	54.6	53.8	0	153	153	0	26	28
2025	10	9	18	33	31	33.6	-1.5	1.073	0.4	0.3	0	54.2	54.2	0	153	153	0	27	27
2025	10	9	18	43	31	32.7	-2.8	1.073	0.4	0.3	0	53.8	54.2	0	152	153	0	27	27
2025	10	9	18	53	31	33.9	-0.7	1.073	0.4	0.3	0	54.2	53.8	0	152	152	0	26	27
2025	10	9	19	3	31	33.1	-1	1.072	0.3	0.2	0	54.2	54.2	0	152	153	0	26	27
2025	10	9	19	13	31	33.1	-1.3	1.072	0.4	0.3	0	54.2	54.2	0	153	153	0	27	27
2025	10	9	19	23	31	32.3	-1.9	1.071	0.5	0.5	0	54.2	54.6	0	153	154	0	27	27
2025	10	9	19	33	31	33.6	-1.9	1.07	0.5	0.4	0	53.8	54.2	0	152	153	0	27	27
2025	10	9	19	43	31	33.4	-2.3	1.07	0.5	0.5	0	54.2	54.2	0	153	153	0	27	27
2025	10	9	19	53	31	33.6	-1.3	1.069	0.3	0.2	0	54.2	54.6	0	153	154	0	27	27
2025	10	9	20	3	31	32.7	-1.7	1.069	0.4	0.3	0	54.6	54.6	0	153	154	0	26	27
2025	10	9	20	13	31	33	-1.6	1.068	0.5	0.4	0	54.6	55	0	153	155	0	26	27
2025	10	9	20	23	31	33.5	-2	1.068	0.5	0.4	0	54.2	54.6	0	153	154	0	27	27
2025	10	9	20	33	31	33.5	-1.3	1.068	0.4	0.3	0	54.2	54.6	0	153	154	0	27	27
2025	10	9	20	43	31	32.3	-1.7	1.068	0.5	0.4	0	54.2	54.6	0	153	154	0	27	27
2025	10	9	20	53	31	32.2	-1.7	1.067	0.4	0.3	0	54.2	55	0	153	155	0	27	27
2025	10	9	21	3	31	32.4	-1.3	1.066	0.3	0.2	0	53.8	54.6	0	153	155	0	28	28
2025	10	9	21	13	31	32.5	-2.1	1.065	0.5	0.4	0	54.6	55	0	153	155	0	26	27
2025	10	9	21	23	31	32.1	-0.9	1.065	0.5	0.4	0	54.2	55.5	0	153	155	0	27	26
2025	10	9	21	33	31	31.6	-0.8	1.064	0.4	0.3	0	54.2	55	0	153	155	0	27	27
2025	10	9	21	43	31	32.9	-1.2	1.064	0.5	0.4	0	55	55	0	154	155	0	26	27
2025	10	9	21	53	31	32	-1.2	1.064	0.4	0.3	0	54.6	55.5	0	154	156	0	27	27
2025	10	9	22	3	31	32.8	-2.9	1.063	0.4	0.3	0	54.6	55	0	154	155	0	27	27
2025	10	9	22	13	31	32.7	-1.5	1.062	0.5	0.4	0	54.6	55	0	154	155	0	27	27
2025	10	9	22	23	31	32.4	-1.7	1.062	0.5	0.4	0	55	55.5	0	155	156	0	27	27
2025	10	9	22	33	31	32.5	-1.3	1.062	0.5	0.4	0	54.6	55	0	154	155	0	27	27
2025	10	9	22	43	31	32.1	-1.4	1.061	0.5	0.5	0	54.6	55.5	0	154	156	0	27	27
2025	10	9	22	53	31	33.2	-1.7	1.06	0.4	0.3	0	54.6	55	0	154	155	0	27	27
2025	10	9	23	3	31	32.9	-1.8	1.06	0.5	0.4	0	54.6	55	0	153	155	0	26	27
2025	10	9	23	13	31	32.4	-1.2	1.06	0.4	0.3	0	54.6	54.6	0	154	155	0	27	28
2025	10	9	23	23	31	32	-1.4	1.06	0.4	0.3	0	54.2	55	0	153	155	0	27	27
2025	10	9	23	33	31	32.6	-0.9	1.058	0.4	0.3	0	54.6	55	0	153	155	0	26	27
2025	10	9	23	43	31	32.1	-1.9	1.059	0.4	0.3	0	53.8	55	0	153	155	0	28	27
2025	10	9	23	53	31	32	-0.4	1.058	0.4	0.3	0	54.6	55	0	153	155	0	26	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	10	0	3	31	32.9	-1.7	1.058	0.5	0.4	0	54.2	55	0	153	155	0	27	27
2025	10	10	0	13	31	32.9	-2.1	1.057	0.4	0.3	0	54.2	54.6	0	153	154	0	27	27
2025	10	10	0	23	31	30.3	-2.2	1.057	0.4	0.3	0	54.2	55	0	153	155	0	27	27
2025	10	10	0	33	31	31.4	-1	1.056	0.3	0.2	0	54.2	55	0	153	155	0	27	27
2025	10	10	0	43	31	33.1	-2.5	1.056	0.5	0.4	0	54.2	54.6	0	153	154	0	27	27
2025	10	10	0	53	31	31.1	-2.3	1.056	0.4	0.3	0	54.2	55	0	153	155	0	27	27
2025	10	10	1	3	31	31.6	-1.7	1.056	0.4	0.3	0	54.2	54.2	0	153	154	0	27	28
2025	10	10	1	13	31	31.6	-1.6	1.055	0.4	0.3	0	54.2	55	0	153	155	0	27	27
2025	10	10	1	23	31	32.8	-2.4	1.055	0.5	0.4	0	54.2	55	0	153	155	0	27	27
2025	10	10	1	33	31	32.6	-3	1.055	0.4	0.3	0	53.8	55	0	152	155	0	27	27
2025	10	10	1	43	31	32.4	-1.6	1.054	0.5	0.4	0	53.8	54.2	0	152	154	0	27	28
2025	10	10	1	53	31	31.9	-1.7	1.055	0.4	0.3	0	54.2	55.5	0	153	155	0	27	26
2025	10	10	2	3	31	31.2	-0.8	1.054	0.5	0.4	0	53.8	54.6	0	152	155	0	27	28
2025	10	10	2	13	31	32.5	-1.7	1.053	0.4	0.3	0	53.8	54.6	0	152	154	0	27	27
2025	10	10	2	23	31	32	-0.9	1.053	0.3	0.2	0	53.8	55	0	152	155	0	27	27
2025	10	10	2	33	31	32.3	-1.7	1.053	0.3	0.2	0	54.2	54.6	0	153	155	0	27	28
2025	10	10	2	43	31	31.5	-2.5	1.053	0.6	0.5	0	53.8	54.6	0	152	154	0	27	27
2025	10	10	2	53	31	31.9	-1	1.052	0.5	0.4	0	54.2	55	0	153	155	0	27	27
2025	10	10	3	3	31	31.7	-1.7	1.051	0.5	0.4	0	53.8	55	0	152	155	0	27	27
2025	10	10	3	13	31	32.3	-2.2	1.051	0.4	0.3	0	53.8	55	0	152	155	0	27	27
2025	10	10	3	23	31	31.7	-0.8	1.051	0.5	0.4	0	53.8	55	0	153	155	0	28	27
2025	10	10	3	33	31	31.9	-2	1.051	0.4	0.3	0	53.8	54.6	0	152	154	0	27	27
2025	10	10	3	43	31	33.1	-2.7	1.05	0.4	0.3	0	53.8	54.6	0	152	154	0	27	27
2025	10	10	3	53	31	31.6	-1.9	1.051	0.4	0.3	0	53.8	55	0	152	155	0	27	27
2025	10	10	4	3	31	32.4	-1.5	1.051	0.4	0.3	0	53.8	55	0	152	155	0	27	27
2025	10	10	4	13	31	32.3	-2.1	1.05	0.3	0.2	0	53.8	55	0	152	155	0	27	27
2025	10	10	4	23	31	32.4	-2	1.05	0.5	0.4	0	53.8	54.6	0	152	154	0	27	27
2025	10	10	4	33	31	31.7	-1.5	1.05	0.4	0.3	0	54.2	54.6	0	152	155	0	26	28
2025	10	10	4	43	31	31.9	-0.6	1.05	0.4	0.3	0	53.8	54.6	0	152	154	0	27	27
2025	10	10	4	53	31	31.4	-1.7	1.049	0.3	0.2	0	54.2	54.6	0	152	154	0	26	27
2025	10	10	5	3	31	31.5	-0.8	1.049	0.5	0.4	0	54.2	54.6	0	152	154	0	26	27
2025	10	10	5	13	31	31.5	-2.5	1.048	0.5	0.4	0	53.8	54.6	0	152	154	0	27	27
2025	10	10	5	23	31	32.1	-1.6	1.048	0.3	0.2	0	53.8	54.6	0	152	154	0	27	27
2025	10	10	5	33	31	31.5	-0.9	1.048	0.5	0.4	0	53.8	55	0	152	154	0	27	26
2025	10	10	5	43	31	32.3	-1.3	1.047	0.5	0.4	0	53.3	54.6	0	151	154	0	27	27
2025	10	10	5	53	31	31.9	-0.7	1.048	0.4	0.3	0	53.3	54.6	0	151	154	0	27	27
2025	10	10	6	3	31	32	-2	1.047	0.4	0.3	0	54.2	54.2	0	152	154	0	26	28
2025	10	10	6	13	31	32.5	-1.2	1.047	0.4	0.3	0	53.3	54.6	0	151	154	0	27	27
2025	10	10	6	23	31	32.8	-1.6	1.046	0.5	0.4	0	53.8	54.6	0	152	154	0	27	27
2025	10	10	6	33	31	30.4	-0.8	1.046	0.4	0.3	0	54.2	55	0	152	155	0	26	27
2025	10	10	6	43	31	31.5	-1.8	1.046	0.4	0.3	0	53.3	55	0	151	155	0	27	27
2025	10	10	6	53	31	30.7	-1.5	1.045	0.4	0.3	0	53.8	55	0	152	155	0	27	27
2025	10	10	7	3	31	31.4	-1	1.045	0.3	0.2	0	53.8	54.6	0	152	154	0	27	27
2025	10	10	7	13	31	32.8	-2	1.045	0.4	0.3	0	53.3	54.6	0	151	154	0	27	27
2025	10	10	7	23	31	32.6	-0.6	1.045	0.3	0.2	0	53.3	54.6	0	150	154	0	26	27
2025	10	10	7	33	31	31.8	-1.7	1.045	0.5	0.4	0	52.9	53.8	0	150	153	0	27	28
2025	10	10	7	43	31	31.9	-1.7	1.045	0.4	0.3	0	52.9	54.2	0	150	153	0	27	27
2025	10	10	7	53	31	32.3	-2.2	1.045	0.5	0.4	0	53.3	54.2	0	150	153	0	26	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	10	8	3	31	31.8	-2.7	1.045	0.3	0.2	0	52.5	53.8	0	149	152	0	27	27
2025	10	10	8	13	31	30.7	-1.5	1.044	0.5	0.4	0	53.3	53.8	0	150	152	0	26	27
2025	10	10	8	23	31	31.9	-2.2	1.044	0.4	0.3	0	52.5	53.8	0	149	152	0	27	27
2025	10	10	8	33	31	31.9	-1	1.045	0.3	0.2	0	52	53.8	0	148	151	0	27	26
2025	10	10	8	43	31	32.3	-2.3	1.045	0.4	0.3	0	52.5	53.3	0	148	151	0	26	27
2025	10	10	8	53	31	31.9	-2.5	1.045	0.4	0.3	0	52	53.3	0	148	151	0	27	27
2025	10	10	9	3	31	30.7	-1.4	1.044	0.5	0.5	0	52.5	53.8	0	149	152	0	27	27
2025	10	10	9	13	31	31.6	-1.9	1.044	0.3	0.2	0	52.9	54.6	0	150	153	0	27	26
2025	10	10	9	23	31	31.9	-0.8	1.044	0.4	0.3	0	52.9	53.8	0	150	152	0	27	27
2025	10	10	9	33	31	31.9	-2.1	1.044	0.5	0.5	0	52.5	53.3	0	149	152	0	27	28
2025	10	10	9	43	31	31.5	-1.7	1.044	0.5	0.4	0	52.5	53.8	0	149	152	0	27	27
2025	10	10	9	53	31	32	-2.4	1.044	0.4	0.3	0	52	53.8	0	148	152	0	27	27
2025	10	10	10	3	31	32.2	-1.8	1.043	0.4	0.3	0	52	53.3	0	148	151	0	27	27
2025	10	10	10	13	31	31.8	-2.2	1.043	0.4	0.3	0	52	53.3	0	148	151	0	27	27
2025	10	10	10	23	31	30.7	-1.9	1.043	0.5	0.5	0	52.5	53.8	0	148	152	0	26	27
2025	10	10	10	33	31	31.3	-1.4	1.043	0.4	0.3	0	52	53.8	0	148	152	0	27	27
2025	10	10	10	43	31	31	-1.9	1.042	0.5	0.4	0	52.9	54.2	0	150	153	0	27	27
2025	10	10	10	53	31	32.1	-2.5	1.043	0.5	0.5	0	52.5	53.8	0	149	152	0	27	27
2025	10	10	11	3	31	31	-2.2	1.043	0.5	0.5	0	52	53.3	0	148	152	0	27	28
2025	10	10	11	13	31	30.6	-2	1.043	0.5	0.4	0	52.5	52.9	0	148	151	0	26	28
2025	10	10	11	23	31	30.9	-2	1.042	0.4	0.3	0	52	53.8	0	148	152	0	27	27
2025	10	10	11	33	31	31.4	-2.5	1.042	0.5	0.4	0	52	53.3	0	148	151	0	27	27
2025	10	10	11	43	31	30.4	-2.1	1.042	0.4	0.3	0	52	53.8	0	148	152	0	27	27
2025	10	10	11	53	31	30.8	-3	1.042	0.4	0.3	0	51.6	53.3	0	147	151	0	27	27
2025	10	10	12	3	31	30.8	-1.3	1.041	0.4	0.3	0	51.6	52.9	0	147	151	0	27	28
2025	10	10	12	13	31	30.5	-1.4	1.042	0.4	0.3	0	51.2	52.9	0	146	150	0	27	27
2025	10	10	12	23	31	30.6	-1	1.041	0.4	0.3	0	51.2	53.3	0	146	150	0	27	26
2025	10	10	12	33	31	31.5	-0.9	1.041	0.5	0.4	0	52	52.9	0	147	150	0	26	27
2025	10	10	12	43	31	32.3	-1.6	1.041	0.5	0.4	0	51.2	53.3	0	146	150	0	27	26
2025	10	10	12	53	31	31	-1.8	1.04	0.4	0.3	0	52	52.9	0	147	150	0	26	27
2025	10	10	13	3	31	30.1	-0.8	1.04	0.3	0.2	0	51.6	53.3	0	147	151	0	27	27
2025	10	10	13	13	31	32	-2.4	1.04	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	10	13	23	31	31.4	-0.8	1.041	0.5	0.4	0	51.6	53.3	0	147	151	0	27	27
2025	10	10	13	33	31	31.8	-2	1.039	0.5	0.4	0	51.6	53.3	0	147	151	0	27	27
2025	10	10	13	43	31	30.5	-0.9	1.04	0.3	0.2	0	52	53.3	0	148	151	0	27	27
2025	10	10	13	53	31	31.2	-1.6	1.039	0.4	0.3	0	52.5	53.8	0	148	151	0	26	26
2025	10	10	14	3	31	30.8	-1.4	1.039	0.5	0.4	0	52.5	53.8	0	148	152	0	26	27
2025	10	10	14	13	31	30.3	-1.9	1.04	0.5	0.4	0	51.6	53.8	0	147	151	0	27	26
2025	10	10	14	23	31	30.9	-2.2	1.038	0.5	0.5	0	51.6	53.3	0	147	151	0	27	27
2025	10	10	14	33	31	31.2	-1	1.038	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	10	14	43	31	31.2	-2.8	1.038	0.4	0.3	0	51.2	52.9	0	146	150	0	27	27
2025	10	10	14	53	31	31.5	-0.9	1.039	0.3	0.2	0	51.6	53.3	0	147	151	0	27	27
2025	10	10	15	3	31	31.6	-2.1	1.038	0.5	0.5	0	51.6	53.3	0	147	151	0	27	27
2025	10	10	15	13	31	31.8	-1.6	1.038	0.5	0.4	0	51.2	53.3	0	146	150	0	27	26
2025	10	10	15	23	31	31.3	-1.4	1.037	0.5	0.4	0	51.6	53.3	0	147	150	0	27	26
2025	10	10	15	33	31	31.8	-1.6	1.038	0.5	0.5	0	51.2	53.3	0	146	150	0	27	26
2025	10	10	15	43	31	30.8	-0.6	1.038	0.5	0.4	0	52	53.3	0	147	151	0	26	27
2025	10	10	15	53	31	31	-1.7	1.039	0.5	0.5	0	52	53.3	0	147	151	0	26	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	10	16	3	31	30.3	-0.4	1.038	0.3	0.2	0	51.6	53.3	0	146	150	0	26	26
2025	10	10	16	13	31	31.8	-2.4	1.037	0.5	0.4	0	51.6	52.9	0	146	150	0	26	27
2025	10	10	16	23	31	30.5	-0.9	1.037	0.4	0.3	0	51.2	52.9	0	145	149	0	26	26
2025	10	10	16	33	31	31.3	-1.3	1.037	0.4	0.3	0	50.7	52.5	0	145	149	0	27	27
2025	10	10	16	43	31	31	-1.7	1.036	0.5	0.4	0	50.7	52.5	0	145	149	0	27	27
2025	10	10	16	53	31	31.9	-1.1	1.037	0.5	0.4	0	51.2	52.5	0	145	149	0	26	27
2025	10	10	17	3	31	30.5	-0.9	1.036	0.4	0.3	0	50.7	52.5	0	145	149	0	27	27
2025	10	10	17	13	31	31	-1.4	1.037	0.4	0.3	0	50.7	52.9	0	145	150	0	27	27
2025	10	10	17	23	31	31.1	-2.2	1.037	0.5	0.5	0	50.3	52.9	0	144	149	0	27	26
2025	10	10	17	33	31	32.2	-0.9	1.037	0.5	0.5	0	50.3	52	0	144	148	0	27	27
2025	10	10	17	43	31	30.7	-2.2	1.036	0.3	0.2	0	50.7	52	0	144	148	0	26	27
2025	10	10	17	53	31	32.3	-1.8	1.036	0.5	0.4	0	50.3	52.5	0	143	148	0	26	26
2025	10	10	18	3	31	31.7	-1.3	1.037	0.4	0.3	0	50.3	52	0	143	148	0	26	27
2025	10	10	18	13	31	31.4	-1.9	1.036	0.5	0.4	0	50.3	51.6	0	143	147	0	26	27
2025	10	10	18	23	31	31	-1.5	1.036	0.5	0.4	0	50.3	52	0	144	148	0	27	27
2025	10	10	18	33	31	31	-1.4	1.037	0.5	0.4	0	48.6	52	0	140	148	0	27	27
2025	10	10	18	43	31	31.7	-1.2	1.036	0.4	0.3	0	52	52.5	0	148	149	0	27	27
2025	10	10	18	53	31	31.8	-0.9	1.036	0.5	0.4	0	52	52.5	0	147	148	0	26	26
2025	10	10	19	3	31	30.9	-1.5	1.036	0.3	0.2	0	51.6	51.6	0	147	147	0	27	27
2025	10	10	19	13	31	31.7	-1.3	1.037	0.5	0.4	0	51.6	52	0	147	148	0	27	27
2025	10	10	19	23	31	31.3	-1.8	1.037	0.3	0.2	0	52	52	0	147	148	0	26	27
2025	10	10	19	33	31	31.9	-1.6	1.037	0.5	0.4	0	52.5	52.9	0	148	149	0	26	26
2025	10	10	19	43	31	31.9	-1.3	1.036	0.5	0.4	0	52.5	52.9	0	148	149	0	26	26
2025	10	10	19	53	31	31.1	-1.9	1.036	0.4	0.3	0	52	52.5	0	148	149	0	27	27
2025	10	10	20	3	31	31.5	-1.8	1.037	0.5	0.5	0	52	52.5	0	148	149	0	27	27
2025	10	10	20	13	31	30.2	-1.2	1.037	0.5	0.4	0	52	52.9	0	148	150	0	27	27
2025	10	10	20	23	31	31.7	-2.5	1.036	0.4	0.3	0	52	52.9	0	148	150	0	27	27
2025	10	10	20	33	31	31.2	-1.3	1.037	0.5	0.4	0	52	52.9	0	148	149	0	27	26
2025	10	10	20	43	31	31.5	-2.2	1.036	0.4	0.3	0	52	52.9	0	148	150	0	27	27
2025	10	10	20	53	31	30.5	-1.8	1.036	0.4	0.3	0	52	52.9	0	148	150	0	27	27
2025	10	10	21	3	31	30.8	-1.8	1.035	0.5	0.4	0	52.5	52.9	0	148	150	0	26	27
2025	10	10	21	13	31	31.1	-1.2	1.036	0.5	0.4	0	52	52.9	0	148	150	0	27	27
2025	10	10	21	23	31	31.8	-2	1.036	0.5	0.5	0	52	52.5	0	148	149	0	27	27
2025	10	10	21	33	31	31.3	-1.7	1.035	0.4	0.3	0	52	52.9	0	148	150	0	27	27
2025	10	10	21	43	31	31.2	-0.9	1.036	0.5	0.4	0	52	52.5	0	148	149	0	27	27
2025	10	10	21	53	31	32.6	-1.8	1.036	0.4	0.3	0	52	53.3	0	148	150	0	27	26
2025	10	10	22	3	31	31.3	-1.3	1.037	0.4	0.3	0	52.5	52.5	0	148	149	0	26	27
2025	10	10	22	13	31	31.1	-1.7	1.036	0.4	0.3	0	51.6	52.5	0	147	149	0	27	27
2025	10	10	22	23	31	31.1	-2	1.036	0.4	0.3	0	52	53.3	0	148	150	0	27	26
2025	10	10	22	33	31	31.5	-1.6	1.036	0.4	0.3	0	52	52.5	0	148	149	0	27	27
2025	10	10	22	43	31	31.3	-1.8	1.035	0.3	0.2	0	51.6	52.5	0	147	149	0	27	27
2025	10	10	22	53	31	31.8	-1	1.036	0.4	0.3	0	52	52.9	0	148	150	0	27	27
2025	10	10	23	3	31	31	-0.9	1.036	0.5	0.4	0	52	53.3	0	148	150	0	27	26
2025	10	10	23	13	31	31.4	-1.3	1.036	0.5	0.4	0	52	52.9	0	148	150	0	27	27
2025	10	10	23	23	31	31.8	-0.8	1.036	0.5	0.4	0	52.5	52.5	0	148	150	0	26	28
2025	10	10	23	33	31	31.1	-1.8	1.036	0.5	0.4	0	52	52.9	0	148	150	0	27	27
2025	10	10	23	43	31	31.4	-1.3	1.036	0.4	0.3	0	51.6	52.5	0	147	149	0	27	27
2025	10	10	23	53	31	32.3	-2	1.036	0.5	0.4	0	51.6	52.5	0	147	149	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	11	0	3	31	31.2	-1.4	1.036	0.5	0.4	0	51.6	52.5	0	147	149	0	27	27
2025	10	11	0	13	31	31	-2.2	1.036	0.3	0.2	0	51.6	52	0	147	149	0	27	28
2025	10	11	0	23	31	31.3	-1.3	1.036	0.4	0.3	0	52	52.5	0	147	149	0	26	27
2025	10	11	0	33	31	31.4	-2.3	1.036	0.5	0.4	0	51.6	52.9	0	147	149	0	27	26
2025	10	11	0	43	31	31.1	-2.3	1.036	0.5	0.5	0	51.6	52.5	0	147	149	0	27	27
2025	10	11	0	53	31	31	-1.7	1.037	0.5	0.4	0	51.6	52	0	147	149	0	27	28
2025	10	11	1	3	31	30.8	-1.3	1.037	0.4	0.3	0	51.6	52	0	147	149	0	27	28
2025	10	11	1	13	31	31.2	-1.4	1.037	0.5	0.5	0	52	52.9	0	147	150	0	26	27
2025	10	11	1	23	31	30.3	-1.7	1.037	0.4	0.3	0	52	53.3	0	148	150	0	27	26
2025	10	11	1	33	31	31.8	-1.3	1.037	0.5	0.4	0	52	53.3	0	147	150	0	26	26
2025	10	11	1	43	31	31	-2.1	1.037	0.5	0.4	0	52	52.9	0	147	150	0	26	27
2025	10	11	1	53	31	31.7	-0.3	1.037	0.4	0.3	0	51.6	53.3	0	147	150	0	27	26
2025	10	11	2	3	31	31.1	-0.9	1.037	0.5	0.4	0	51.6	52.9	0	147	150	0	27	27
2025	10	11	2	13	31	30.9	-1.3	1.037	0.3	0.2	0	51.6	52	0	147	149	0	27	28
2025	10	11	2	23	31	30.9	-1.2	1.038	0.5	0.4	0	52	53.3	0	148	150	0	27	26
2025	10	11	2	33	31	30.6	-1	1.038	0.5	0.4	0	51.6	52	0	147	149	0	27	28
2025	10	11	2	43	31	32.2	-0.6	1.039	0.5	0.4	0	52	52.9	0	147	150	0	26	27
2025	10	11	2	53	31	31.7	-0.4	1.038	0.5	0.4	0	52.5	52.9	0	148	150	0	26	27
2025	10	11	3	3	31	32.2	-2.4	1.038	0.5	0.5	0	51.6	52.9	0	147	150	0	27	27
2025	10	11	3	13	31	31.3	-1.7	1.039	0.3	0.2	0	51.6	52.5	0	147	149	0	27	27
2025	10	11	3	23	31	30.6	-1.7	1.039	0.5	0.4	0	52	53.3	0	147	150	0	26	26
2025	10	11	3	33	31	31.6	-1.8	1.039	0.5	0.4	0	51.6	52.9	0	147	150	0	27	27
2025	10	11	3	43	31	31.5	-1.3	1.039	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	11	3	53	31	30.9	-1.7	1.04	0.5	0.4	0	51.6	52.9	0	147	150	0	27	27
2025	10	11	4	3	31	31.5	-1.9	1.039	0.5	0.4	0	51.6	52.9	0	147	150	0	27	27
2025	10	11	4	13	31	29.6	-2.5	1.04	0.6	0.5	0	51.6	52.9	0	147	150	0	27	27
2025	10	11	4	23	31	31.4	-1.8	1.04	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	11	4	33	31	30.9	-1.3	1.04	0.5	0.4	0	52	52.5	0	147	149	0	26	27
2025	10	11	4	43	31	31.7	-2.5	1.04	0.5	0.4	0	52	52.9	0	147	150	0	26	27
2025	10	11	4	53	31	31.6	-2.2	1.04	0.5	0.4	0	51.6	52.9	0	147	150	0	27	27
2025	10	11	5	3	31	30.9	-1.5	1.04	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	11	5	13	31	31.7	-1.1	1.04	0.5	0.5	0	52	52.9	0	147	150	0	26	27
2025	10	11	5	23	31	32	-0.6	1.04	0.5	0.4	0	51.6	52.9	0	147	150	0	27	27
2025	10	11	5	33	31	31	0	1.04	0.5	0.4	0	51.6	52.9	0	147	150	0	27	27
2025	10	11	5	43	31	31.6	-2.5	1.04	0.3	0.2	0	51.6	52.9	0	147	150	0	27	27
2025	10	11	5	53	31	32.6	-2.2	1.04	0.5	0.4	0	52	52.5	0	147	149	0	26	27
2025	10	11	6	3	31	31.6	-1.4	1.04	0.5	0.4	0	51.6	52	0	147	149	0	27	28
2025	10	11	6	13	31	31.4	-2.6	1.04	0.5	0.4	0	51.2	52.5	0	146	149	0	27	27
2025	10	11	6	23	31	32.4	-1.5	1.04	0.5	0.4	0	52	52.5	0	147	150	0	26	28
2025	10	11	6	33	31	32.4	-1.3	1.04	0.4	0.3	0	51.6	52.5	0	147	149	0	27	27
2025	10	11	6	43	31	31.9	-1	1.04	0.4	0.3	0	51.2	52.9	0	147	150	0	28	27
2025	10	11	6	53	31	30.6	-1.4	1.04	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	11	7	3	31	32.1	-1.7	1.04	0.4	0.3	0	52	52.5	0	147	149	0	26	27
2025	10	11	7	13	31	31	-1.9	1.041	0.3	0.2	0	52	52.9	0	147	150	0	26	27
2025	10	11	7	23	31	32.3	-2	1.04	0.5	0.4	0	51.2	52.5	0	146	149	0	27	27
2025	10	11	7	33	31	30.9	-1.8	1.04	0.5	0.4	0	51.2	52.5	0	146	149	0	27	27
2025	10	11	7	43	31	31.2	-2	1.041	0.4	0.3	0	50.7	52	0	145	148	0	27	27
2025	10	11	7	53	31	30.3	-1.6	1.04	0.3	0.2	0	51.6	52	0	146	148	0	26	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	11	8	3	31	32.1	-0.4	1.04	0.3	0.2	0	50.7	52	0	145	148	0	27	27
2025	10	11	8	13	31	30.6	-2.5	1.04	0.3	0.2	0	50.7	52	0	145	148	0	27	27
2025	10	11	8	23	31	31.2	-1.5	1.041	0.4	0.3	0	50.3	52	0	144	147	0	27	26
2025	10	11	8	33	31	30.5	-1.1	1.041	0.3	0.2	0	50.3	52	0	144	147	0	27	26
2025	10	11	8	43	31	31.8	-0.8	1.041	0.3	0.2	0	49.9	51.2	0	143	146	0	27	27
2025	10	11	8	53	31	31	-1.7	1.041	0.4	0.3	0	49.9	51.2	0	143	146	0	27	27
2025	10	11	9	3	31	32.4	-1.7	1.041	0.4	0.3	0	49.5	50.7	0	142	145	0	27	27
2025	10	11	9	13	31	31.1	-1.7	1.041	0.5	0.4	0	49.9	50.7	0	143	145	0	27	27
2025	10	11	9	23	31	31	-1.7	1.041	0.4	0.3	0	49.9	50.7	0	142	145	0	26	27
2025	10	11	9	33	31	31.4	-0.9	1.041	0.3	0.2	0	49.5	50.3	0	142	145	0	27	28
2025	10	11	9	43	31	29.3	-0.9	1.041	0.3	0.2	0	49.5	50.7	0	142	145	0	27	27
2025	10	11	9	53	31	32	-2.2	1.041	0.5	0.4	0	49	50.3	0	141	144	0	27	27
2025	10	11	10	3	31	31.8	-1.9	1.041	0.5	0.4	0	49.5	50.7	0	142	145	0	27	27
2025	10	11	10	13	31	31.5	-1.3	1.041	0.4	0.3	0	49.5	50.7	0	142	145	0	27	27
2025	10	11	10	23	31	30.1	-0.9	1.041	0.4	0.3	0	49	50.7	0	142	145	0	28	27
2025	10	11	10	33	31	30.9	-1.8	1.041	0.4	0.3	0	49.5	50.7	0	142	144	0	27	26
2025	10	11	10	43	31	32.3	-1.7	1.041	0.4	0.3	0	49	49.9	0	141	144	0	27	28
2025	10	11	10	53	31	31	-2.1	1.041	0.5	0.4	0	49	50.3	0	141	144	0	27	27
2025	10	11	11	3	31	30.7	-0.9	1.041	0.5	0.4	0	49	50.3	0	141	144	0	27	27
2025	10	11	11	13	31	30.5	-1.7	1.041	0.5	0.4	0	49	50.3	0	141	144	0	27	27
2025	10	11	11	23	31	30.8	-1.4	1.041	0.3	0.2	0	49	49.9	0	141	144	0	27	28
2025	10	11	11	33	31	31.4	-1.2	1.041	0.5	0.4	0	49	50.3	0	140	144	0	26	27
2025	10	11	11	43	31	31	-0.9	1.041	0.4	0.3	0	48.6	50.3	0	140	144	0	27	27
2025	10	11	11	53	31	31.4	-0.4	1.041	0.3	0.2	0	49.5	50.3	0	141	144	0	26	27
2025	10	11	12	3	31	31.1	-0.9	1.041	0.4	0.3	0	48.6	49.9	0	140	143	0	27	27
2025	10	11	12	13	31	31	-0.6	1.041	0.4	0.3	0	49	50.3	0	141	144	0	27	27
2025	10	11	12	23	31	30.4	-1.3	1.041	0.5	0.4	0	48.6	49.9	0	140	144	0	27	28
2025	10	11	12	33	31	30.8	-0.7	1.041	0.5	0.4	0	48.6	50.3	0	140	144	0	27	27
2025	10	11	12	43	31	32.1	-0.9	1.04	0.3	0.2	0	49.5	50.7	0	142	145	0	27	27
2025	10	11	12	53	31	31	-1.3	1.04	0.3	0.2	0	50.3	51.2	0	143	146	0	26	27
2025	10	11	13	3	31	31.3	-0.9	1.039	0.5	0.4	0	50.3	52	0	144	148	0	27	27
2025	10	11	13	13	31	30.4	-1.2	1.039	0.5	0.5	0	50.3	52	0	144	148	0	27	27
2025	10	11	13	23	31	32	-2.1	1.038	0.4	0.3	0	53.8	55	0	152	156	0	27	28
2025	10	11	13	33	31	31.7	-0.5	1.039	0.4	0.3	0	54.6	55.9	0	154	157	0	27	27
2025	10	11	13	43	31	31.3	-1.7	1.038	0.6	0.5	0	54.6	55.9	0	154	157	0	27	27
2025	10	11	13	53	31	31.2	-1.9	1.038	0.5	0.5	0	54.2	55.5	0	152	156	0	26	27
2025	10	11	14	3	31	31.4	-1.3	1.039	0.4	0.3	0	52.9	54.2	0	149	153	0	26	27
2025	10	11	14	13	31	31.1	-1.2	1.039	0.5	0.4	0	51.6	53.3	0	147	151	0	27	27
2025	10	11	14	23	31	31.2	-0.9	1.039	0.4	0.3	0	51.2	52.5	0	145	149	0	26	27
2025	10	11	14	33	31	30.7	-1.3	1.039	0.3	0.2	0	50.7	52	0	145	148	0	27	27
2025	10	11	14	43	31	31.4	-1.5	1.038	0.3	0.2	0	50.3	52	0	144	148	0	27	27
2025	10	11	14	53	31	30.9	-0.6	1.037	0.4	0.3	0	51.2	52.9	0	145	149	0	26	26
2025	10	11	15	3	31	29.9	-1.9	1.037	0.4	0.3	0	50.7	52.5	0	145	149	0	27	27
2025	10	11	15	13	31	31.5	-1.3	1.036	0.4	0.3	0	50.7	52	0	145	148	0	27	27
2025	10	11	15	23	31	31.9	-0.7	1.036	0.4	0.3	0	50.7	52	0	145	148	0	27	27
2025	10	11	15	33	31	31.6	-2	1.036	0.4	0.3	0	50.7	52	0	145	148	0	27	27
2025	10	11	15	43	31	31.1	-1.7	1.036	0.4	0.3	0	50.7	52.5	0	145	149	0	27	27
2025	10	11	15	53	31	30.5	-1.8	1.036	0.4	0.3	0	51.2	52.5	0	146	149	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	11	16	3	31	31.4	-1.3	1.037	0.5	0.4	0	51.2	52.5	0	145	149	0	26	27
2025	10	11	16	13	31	31.1	-1.3	1.036	0.5	0.4	0	50.7	52.5	0	145	149	0	27	27
2025	10	11	16	23	31	31.2	-2.1	1.036	0.5	0.4	0	50.3	51.6	0	144	147	0	27	27
2025	10	11	16	33	31	31.9	-1.3	1.036	0.5	0.4	0	50.7	52	0	144	148	0	26	27
2025	10	11	16	43	31	31.6	-2	1.036	0.5	0.4	0	50.3	52	0	144	148	0	27	27
2025	10	11	16	53	31	31.4	-1.9	1.036	0.4	0.3	0	50.7	51.6	0	145	148	0	27	28
2025	10	11	17	3	31	31.6	-2.6	1.035	0.5	0.4	0	50.7	52	0	145	148	0	27	27
2025	10	11	17	13	31	32	-1.4	1.035	0.5	0.4	0	50.7	52.5	0	145	149	0	27	27
2025	10	11	17	23	31	31	-2.3	1.035	0.3	0.2	0	51.2	52.5	0	145	149	0	26	27
2025	10	11	17	33	31	31.5	-0.8	1.035	0.4	0.3	0	50.7	52	0	145	148	0	27	27
2025	10	11	17	43	31	31.5	-1.9	1.035	0.5	0.4	0	51.2	52.5	0	145	149	0	26	27
2025	10	11	17	53	31	31.7	-1.9	1.035	0.4	0.3	0	50.3	51.6	0	144	147	0	27	27
2025	10	11	18	3	31	31.6	-1.5	1.035	0.5	0.5	0	50.3	52.5	0	144	148	0	27	26
2025	10	11	18	13	31	31.2	-1.4	1.035	0.5	0.4	0	50.3	52	0	144	148	0	27	27
2025	10	11	18	23	31	31.2	-2.2	1.035	0.5	0.4	0	50.7	51.6	0	144	148	0	26	28
2025	10	11	18	33	31	30.7	-0.8	1.035	0.5	0.4	0	50.7	52.5	0	144	148	0	26	26
2025	10	11	18	43	31	30.9	-0.6	1.035	0.4	0.3	0	50.7	52	0	144	148	0	26	27
2025	10	11	18	53	31	30.3	-1	1.035	0.4	0.3	0	50.7	52.5	0	145	149	0	27	27
2025	10	11	19	3	31	31.3	-2.1	1.035	0.5	0.4	0	50.3	52	0	144	148	0	27	27
2025	10	11	19	13	31	31.5	-1.6	1.035	0.5	0.4	0	50.7	52.5	0	145	149	0	27	27
2025	10	11	19	23	31	32.4	-1.7	1.035	0.5	0.4	0	50.7	52.9	0	145	149	0	27	26
2025	10	11	19	33	31	30.6	-1.5	1.036	0.5	0.5	0	51.6	52.9	0	146	150	0	26	27
2025	10	11	19	43	31	30.9	-1.2	1.035	0.4	0.3	0	51.2	52.9	0	146	150	0	27	27
2025	10	11	19	53	31	31.3	-1.1	1.035	0.5	0.4	0	51.6	53.3	0	146	151	0	26	27
2025	10	11	20	3	31	32.2	-2.6	1.035	0.6	0.5	0	51.2	52.5	0	145	149	0	26	27
2025	10	11	20	13	31	31.1	-1.3	1.036	0.3	0.2	0	51.6	52.9	0	146	150	0	26	27
2025	10	11	20	23	31	31.2	-1.7	1.036	0.4	0.3	0	53.3	52.9	0	150	151	0	26	28
2025	10	11	20	33	31	32.1	-0.9	1.036	0.4	0.3	0	52.9	53.3	0	150	151	0	27	27
2025	10	11	20	43	31	31	-0.9	1.035	0.6	0.5	0	52.9	53.3	0	150	151	0	27	27
2025	10	11	20	53	31	29.9	-1.3	1.036	0.5	0.4	0	53.3	54.2	0	151	152	0	27	26
2025	10	11	21	3	31	31.1	0	1.037	0.3	0.2	0	53.8	53.8	0	151	152	0	26	27
2025	10	11	21	13	31	31.1	-2.1	1.036	0.4	0.3	0	52.9	53.3	0	150	151	0	27	27
2025	10	11	21	23	31	30.6	-0.7	1.036	0.4	0.3	0	53.3	53.8	0	150	152	0	26	27
2025	10	11	21	33	31	31.3	-2.7	1.036	0.5	0.4	0	52.9	52.9	0	150	151	0	27	28
2025	10	11	21	43	31	30.8	-1.1	1.037	0.4	0.3	0	52.9	53.3	0	150	151	0	27	27
2025	10	11	21	53	31	31	-2.9	1.036	0.5	0.4	0	52.5	51.6	0	149	148	0	27	28
2025	10	11	22	3	31	30.6	-0.9	1.036	0.3	0.2	0	52.5	52.5	0	149	149	0	27	27
2025	10	11	22	13	31	31.7	-1.7	1.036	0.6	0.5	0	52.5	52.5	0	149	149	0	27	27
2025	10	11	22	23	31	30.2	-0.6	1.036	0.4	0.3	0	52.9	52	0	149	149	0	26	28
2025	10	11	22	33	31	31.6	-0.9	1.036	0.5	0.4	0	52.5	53.3	0	149	151	0	27	27
2025	10	11	22	43	31	31.5	-0.4	1.036	0.5	0.4	0	52	52.9	0	148	151	0	27	28
2025	10	11	22	53	31	30.8	-1.3	1.036	0.5	0.4	0	52.5	53.8	0	149	152	0	27	27
2025	10	11	23	3	31	31.2	-1.5	1.037	0.4	0.3	0	51.6	53.3	0	148	151	0	28	27
2025	10	11	23	13	31	31.2	-2	1.036	0.5	0.4	0	52	53.3	0	148	151	0	27	27
2025	10	11	23	23	31	30.7	-1.2	1.037	0.5	0.5	0	52.5	52.9	0	148	151	0	26	28
2025	10	11	23	33	31	31.5	-1.8	1.037	0.4	0.3	0	52.5	52.9	0	148	151	0	26	28
2025	10	11	23	43	31	31.5	-0.2	1.036	0.4	0.3	0	52	52.9	0	148	151	0	27	28
2025	10	11	23	53	31	32.2	-1.7	1.036	0.3	0.2	0	52	53.8	0	148	152	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	12	0	3	31	30.7	-2	1.036	0.5	0.4	0	52	53.3	0	148	152	0	27	28
2025	10	12	0	13	31	30.5	0	1.037	0.3	0.2	0	52	53.3	0	148	152	0	27	28
2025	10	12	0	23	31	30.3	-2.1	1.037	0.4	0.3	0	51.6	53.3	0	147	151	0	27	27
2025	10	12	0	33	31	30.2	-1.5	1.037	0.3	0.2	0	52	53.8	0	148	152	0	27	27
2025	10	12	0	43	31	31.3	-1.3	1.037	0.5	0.4	0	52	53.3	0	148	151	0	27	27
2025	10	12	0	53	31	31.5	-2	1.037	0.4	0.3	0	51.6	53.3	0	147	151	0	27	27
2025	10	12	1	3	31	31.2	-1.6	1.037	0.4	0.3	0	51.6	53.3	0	147	151	0	27	27
2025	10	12	1	13	31	30.5	-0.5	1.037	0.4	0.3	0	52	53.3	0	148	151	0	27	27
2025	10	12	1	23	31	30.5	-2.1	1.037	0.3	0.2	0	51.6	52.9	0	147	151	0	27	28
2025	10	12	1	33	31	31.2	-1.3	1.038	0.5	0.4	0	51.6	52.9	0	147	151	0	27	28
2025	10	12	1	43	31	30.6	-1.1	1.037	0.5	0.5	0	52	53.8	0	148	151	0	27	26
2025	10	12	1	53	31	31.5	-1.3	1.037	0.4	0.3	0	51.6	53.3	0	147	151	0	27	27
2025	10	12	2	3	31	31.1	-1.7	1.037	0.3	0.2	0	51.6	53.3	0	147	151	0	27	27
2025	10	12	2	13	31	30.5	-1.5	1.037	0.4	0.3	0	52	53.3	0	148	151	0	27	27
2025	10	12	2	23	31	30.6	-1.7	1.037	0.3	0.2	0	51.6	53.3	0	147	152	0	27	28
2025	10	12	2	33	31	31	-2.3	1.037	0.4	0.3	0	52	53.8	0	148	152	0	27	27
2025	10	12	2	43	31	30.3	-1.3	1.037	0.5	0.4	0	52	53.8	0	148	152	0	27	27
2025	10	12	2	53	31	30.6	-1.6	1.037	0.4	0.3	0	52	53.8	0	148	152	0	27	27
2025	10	12	3	3	31	31.9	-0.9	1.037	0.5	0.4	0	52	54.2	0	148	153	0	27	27
2025	10	12	3	13	31	31.8	-2.5	1.037	0.4	0.3	0	51.6	53.8	0	147	152	0	27	27
2025	10	12	3	23	31	31.6	-1.2	1.037	0.5	0.4	0	51.6	53.3	0	147	151	0	27	27
2025	10	12	3	33	31	31.3	-2.3	1.037	0.4	0.3	0	51.6	53.3	0	147	151	0	27	27
2025	10	12	3	43	31	31	-1.7	1.037	0.5	0.4	0	51.6	52.9	0	147	151	0	27	28
2025	10	12	3	53	31	30.7	-2.1	1.037	0.4	0.3	0	51.6	53.3	0	147	152	0	27	28
2025	10	12	4	3	31	30.9	-1.7	1.037	0.5	0.4	0	51.6	53.3	0	147	151	0	27	27
2025	10	12	4	13	31	30.7	-1.6	1.037	0.5	0.4	0	51.6	53.3	0	147	152	0	27	28
2025	10	12	4	23	31	30.9	-1.9	1.037	0.5	0.5	0	51.6	53.3	0	147	151	0	27	27
2025	10	12	4	33	31	31.7	-0.7	1.038	0.4	0.3	0	51.6	53.3	0	147	151	0	27	27
2025	10	12	4	43	31	31.9	-1.2	1.037	0.5	0.4	0	51.6	52.9	0	147	151	0	27	28
2025	10	12	4	53	31	30.9	-1.5	1.037	0.4	0.3	0	51.6	52.9	0	147	151	0	27	28
2025	10	12	5	3	31	30.9	-1.6	1.037	0.5	0.4	0	51.2	52.9	0	147	151	0	28	28
2025	10	12	5	13	31	31.3	-0.5	1.037	0.4	0.3	0	51.6	53.3	0	147	152	0	27	28
2025	10	12	5	23	31	30.4	-2	1.037	0.3	0.2	0	51.2	53.3	0	146	151	0	27	27
2025	10	12	5	33	31	31.1	-2.3	1.038	0.4	0.3	0	51.2	53.3	0	146	151	0	27	27
2025	10	12	5	43	31	30.9	-0.9	1.038	0.3	0.2	0	51.2	52.5	0	146	150	0	27	28
2025	10	12	5	53	31	30.6	-1.8	1.038	0.4	0.3	0	51.2	53.3	0	146	151	0	27	27
2025	10	12	6	3	31	30.1	-0.7	1.037	0.5	0.5	0	50.7	52.9	0	146	151	0	28	28
2025	10	12	6	13	31	31.6	-1.5	1.037	0.4	0.3	0	51.6	52.5	0	147	150	0	27	28
2025	10	12	6	23	31	30.8	-1.7	1.037	0.5	0.4	0	51.6	52.5	0	147	150	0	27	28
2025	10	12	6	33	31	30.4	-1.7	1.037	0.5	0.4	0	51.2	52.9	0	147	150	0	28	27
2025	10	12	6	43	31	31	-1.6	1.037	0.5	0.4	0	51.2	52.5	0	147	150	0	28	28
2025	10	12	6	53	31	31.1	-1.4	1.037	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	12	7	3	31	31.4	-1	1.037	0.5	0.5	0	51.6	52.9	0	147	150	0	27	27
2025	10	12	7	13	31	30.7	-2.5	1.037	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	12	7	23	31	31.2	-1	1.037	0.3	0.2	0	50.7	52.5	0	146	150	0	28	28
2025	10	12	7	33	31	29.9	-1.2	1.037	0.4	0.3	0	51.2	52	0	146	149	0	27	28
2025	10	12	7	43	31	31.9	-1.5	1.037	0.4	0.3	0	51.2	52	0	146	149	0	27	28
2025	10	12	7	53	31	31.1	-1.4	1.037	0.3	0.2	0	50.3	52.5	0	145	149	0	28	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	12	8	3	31	31.7	-2.5	1.037	0.5	0.4	0	50.7	51.6	0	146	148	0	28	28
2025	10	12	8	13	31	31.1	-2.5	1.037	0.4	0.3	0	50.7	52	0	145	148	0	27	27
2025	10	12	8	23	31	31.7	-2	1.037	0.4	0.3	0	50.7	51.6	0	145	148	0	27	28
2025	10	12	8	33	31	30.7	-1.4	1.037	0.5	0.4	0	50.3	51.6	0	144	147	0	27	27
2025	10	12	8	43	31	31.1	-1.7	1.037	0.5	0.4	0	49.9	51.2	0	143	146	0	27	27
2025	10	12	8	53	31	31.5	-2.2	1.037	0.4	0.3	0	49.5	50.7	0	143	146	0	28	28
2025	10	12	9	3	31	32.1	-1.2	1.037	0.5	0.4	0	49.9	50.7	0	143	146	0	27	28
2025	10	12	9	13	31	31.9	-1.9	1.037	0.5	0.4	0	49.5	51.2	0	143	146	0	28	27
2025	10	12	9	23	31	30.7	-2.1	1.037	0.4	0.3	0	49.5	50.7	0	142	146	0	27	28
2025	10	12	9	33	31	30.4	-1	1.037	0.4	0.3	0	49.5	50.3	0	142	145	0	27	28
2025	10	12	9	43	31	31.3	-3.3	1.037	0.4	0.3	0	48.6	49.9	0	141	144	0	28	28
2025	10	12	9	53	31	32	-2.1	1.037	0.5	0.4	0	48.6	49.9	0	140	144	0	27	28
2025	10	12	10	3	31	31.5	-2.5	1.038	0.5	0.4	0	48.6	49.9	0	140	144	0	27	28
2025	10	12	10	13	31	31	-1.2	1.038	0.5	0.4	0	48.2	50.3	0	140	144	0	28	27
2025	10	12	10	23	31	30.8	-1.4	1.038	0.5	0.5	0	49	50.3	0	141	145	0	27	28
2025	10	12	10	33	31	32	-1.1	1.038	0.4	0.3	0	48.2	49.9	0	140	143	0	28	27
2025	10	12	10	43	31	30.5	-0.8	1.038	0.5	0.4	0	48.6	49.9	0	140	143	0	27	27
2025	10	12	10	53	31	30.8	-1.1	1.038	0.5	0.5	0	48.2	49.5	0	139	143	0	27	28
2025	10	12	11	3	31	31.6	-1.3	1.038	0.3	0.2	0	48.2	49.5	0	138	142	0	26	27
2025	10	12	11	13	31	31.1	-1.3	1.038	0.4	0.3	0	47.7	49.5	0	138	142	0	27	27
2025	10	12	11	23	31	31	-1.2	1.038	0.5	0.5	0	47.7	49.5	0	138	142	0	27	27
2025	10	12	11	33	31	31.7	-1.7	1.038	0.6	0.5	0	47.7	49.5	0	138	142	0	27	27
2025	10	12	11	43	31	30.9	-1.4	1.038	0.5	0.4	0	48.2	49	0	139	142	0	27	28
2025	10	12	11	53	31	32.4	-1.3	1.038	0.5	0.4	0	47.3	48.6	0	138	141	0	28	28
2025	10	12	12	3	31	31.3	-2.5	1.038	0.5	0.4	0	47.7	49	0	138	142	0	27	28
2025	10	12	12	13	31	31.7	-2.1	1.038	0.5	0.4	0	47.7	49	0	138	141	0	27	27
2025	10	12	12	23	31	30.7	-2.4	1.038	0.5	0.4	0	47.7	48.6	0	138	141	0	27	28
2025	10	12	12	33	31	31.8	-2.2	1.038	0.5	0.5	0	47.7	49.5	0	138	142	0	27	27
2025	10	12	12	43	31	31.4	-2.1	1.038	0.3	0.2	0	47.7	49.5	0	138	142	0	27	27
2025	10	12	12	53	31	31	-1.6	1.038	0.4	0.3	0	47.7	49.5	0	138	142	0	27	27
2025	10	12	13	3	31	31.9	-2.5	1.038	0.4	0.3	0	47.7	49	0	138	142	0	27	28
2025	10	12	13	13	31	31.3	-1.6	1.038	0.4	0.3	0	47.3	48.6	0	138	141	0	28	28
2025	10	12	13	23	31	30.7	-2.2	1.038	0.3	0.2	0	47.3	48.6	0	137	141	0	27	28
2025	10	12	13	33	31	31.1	-2	1.038	0.4	0.3	0	47.3	49.5	0	138	142	0	28	27
2025	10	12	13	43	31	29.9	-1.3	1.038	0.5	0.5	0	47.7	49.5	0	138	142	0	27	27
2025	10	12	13	53	31	31.2	-1.5	1.038	0.4	0.3	0	47.7	49	0	138	142	0	27	28
2025	10	12	14	3	31	32.1	-1.2	1.038	0.5	0.4	0	47.7	49.5	0	138	142	0	27	27
2025	10	12	14	13	31	31.3	-2	1.038	0.5	0.4	0	47.7	49.9	0	138	142	0	27	26
2025	10	12	14	23	31	32.2	-1.3	1.037	0.4	0.3	0	47.7	48.6	0	138	141	0	27	28
2025	10	12	14	33	31	31.5	-0.8	1.037	0.5	0.5	0	47.7	49	0	138	142	0	27	28
2025	10	12	14	43	31	31.1	-1.1	1.037	0.4	0.3	0	48.2	49.5	0	139	142	0	27	27
2025	10	12	14	53	31	31.7	-2.1	1.037	0.4	0.3	0	48.2	50.3	0	139	144	0	27	27
2025	10	12	15	3	31	31	-2.1	1.037	0.4	0.3	0	48.6	49.9	0	140	144	0	27	28
2025	10	12	15	13	31	30.8	-2.1	1.037	0.5	0.4	0	48.6	50.3	0	140	144	0	27	27
2025	10	12	15	23	31	31.7	-1.5	1.037	0.3	0.2	0	48.6	50.3	0	140	144	0	27	27
2025	10	12	15	33	31	31.3	-2.6	1.036	0.5	0.4	0	48.2	50.3	0	139	144	0	27	27
2025	10	12	15	43	31	31.1	-1.6	1.036	0.4	0.3	0	48.6	50.3	0	140	144	0	27	27
2025	10	12	15	53	31	31	-2.1	1.036	0.5	0.4	0	49	50.7	0	141	145	0	27	27

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	12	16	3	31	31.2	-1.3	1.036	0.4	0.3	0	49	50.7	0	141	145	0	27	27
2025	10	12	16	13	31	32.4	-2.1	1.036	0.4	0.3	0	49	50.7	0	141	145	0	27	27
2025	10	12	16	23	31	30.2	-1.3	1.035	0.3	0.2	0	48.6	50.7	0	141	145	0	28	27
2025	10	12	16	33	31	31.8	-1.2	1.036	0.3	0.2	0	49.5	51.2	0	142	146	0	27	27
2025	10	12	16	43	31	31.8	-2.1	1.036	0.5	0.4	0	49.5	51.2	0	142	146	0	27	27
2025	10	12	16	53	31	30.4	-1.7	1.035	0.4	0.3	0	49	50.7	0	142	146	0	28	28
2025	10	12	17	3	31	30.9	-2.1	1.035	0.3	0.2	0	49.5	51.2	0	142	146	0	27	27
2025	10	12	17	13	31	31.3	-2.2	1.035	0.4	0.3	0	49.5	50.7	0	142	146	0	27	28
2025	10	12	17	23	31	30.4	-1.8	1.035	0.4	0.3	0	49.5	51.6	0	142	147	0	27	27
2025	10	12	17	33	31	30.9	-1.8	1.034	0.4	0.3	0	49.9	51.2	0	143	147	0	27	28
2025	10	12	17	43	31	31.1	-1.1	1.036	0.4	0.3	0	49.5	51.6	0	142	147	0	27	27
2025	10	12	17	53	31	31.3	-1.8	1.036	0.3	0.2	0	49	51.6	0	142	147	0	28	27
2025	10	12	18	3	31	31.6	-1.3	1.036	0.5	0.4	0	49.5	51.6	0	142	147	0	27	27
2025	10	12	18	13	31	30.6	-0.8	1.036	0.4	0.3	0	50.3	51.2	0	143	147	0	26	28
2025	10	12	18	23	31	32.3	-1.3	1.036	0.5	0.4	0	49.5	51.6	0	142	147	0	27	27
2025	10	12	18	33	31	29.4	-1.8	1.035	0.4	0.3	0	49.9	51.6	0	143	147	0	27	27
2025	10	12	18	43	31	30.9	-0.8	1.036	0.5	0.4	0	49.9	51.6	0	143	147	0	27	27
2025	10	12	18	53	31	30.6	-1.3	1.036	0.5	0.5	0	49.9	51.6	0	143	147	0	27	27
2025	10	12	19	3	31	31	-2.1	1.037	0.5	0.4	0	50.3	52	0	144	148	0	27	27
2025	10	12	19	13	31	31.7	-2.2	1.037	0.3	0.2	0	49.5	52	0	143	148	0	28	27
2025	10	12	19	23	31	30.9	-1.6	1.037	0.3	0.2	0	50.3	52	0	144	148	0	27	27
2025	10	12	19	33	31	30.5	-1.5	1.036	0.4	0.3	0	50.3	52.5	0	144	149	0	27	27
2025	10	12	19	43	31	31.6	-2.5	1.036	0.5	0.4	0	50.3	52.5	0	144	149	0	27	27
2025	10	12	19	53	31	30.2	-2.1	1.036	0.5	0.4	0	50.7	52.5	0	145	149	0	27	27
2025	10	12	20	3	31	30.4	-1.3	1.036	0.5	0.4	0	50.7	52.5	0	145	149	0	27	27
2025	10	12	20	13	31	31.1	-1.7	1.036	0.4	0.3	0	51.2	52.5	0	146	149	0	27	27
2025	10	12	20	23	31	30	-0.9	1.036	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	12	20	33	31	31.8	-1.5	1.036	0.5	0.4	0	51.2	52.9	0	146	150	0	27	27
2025	10	12	20	43	31	30.1	-1.8	1.036	0.4	0.3	0	51.2	52.9	0	146	150	0	27	27
2025	10	12	20	53	31	31.3	-1.3	1.036	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	12	21	3	31	30.5	-1	1.036	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	12	21	13	31	31.3	-1.6	1.036	0.4	0.3	0	51.2	52.9	0	146	150	0	27	27
2025	10	12	21	23	31	30.4	-1.7	1.036	0.5	0.4	0	51.6	52.5	0	147	150	0	27	28
2025	10	12	21	33	31	30.2	-1.7	1.036	0.4	0.3	0	51.6	52.5	0	147	150	0	27	28
2025	10	12	21	43	31	31.1	-2.5	1.036	0.3	0.2	0	51.2	52.5	0	146	150	0	27	28
2025	10	12	21	53	31	30.7	-1.1	1.036	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	12	22	3	31	30.1	-1.7	1.036	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	12	22	13	31	30.5	-1.1	1.036	0.4	0.3	0	51.2	52.9	0	146	150	0	27	27
2025	10	12	22	23	31	31.3	-1.2	1.036	0.5	0.4	0	51.2	52.9	0	146	150	0	27	27
2025	10	12	22	33	31	31.9	-1	1.036	0.4	0.3	0	50.7	52.5	0	146	150	0	28	28
2025	10	12	22	43	31	30.8	-1.2	1.036	0.4	0.3	0	51.6	52.9	0	147	151	0	27	28
2025	10	12	22	53	31	31.2	-2	1.036	0.5	0.4	0	51.2	52.9	0	146	150	0	27	27
2025	10	12	23	3	31	31	-1.2	1.036	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	12	23	13	31	31.1	-0.9	1.036	0.3	0.2	0	51.2	52.9	0	146	150	0	27	27
2025	10	12	23	23	31	30.7	-1.9	1.036	0.4	0.3	0	51.2	52.9	0	146	150	0	27	27
2025	10	12	23	33	31	30.6	-1.5	1.036	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	12	23	43	31	31.1	-1.7	1.035	0.5	0.4	0	51.2	52.5	0	146	150	0	27	28
2025	10	12	23	53	31	31.5	-2	1.035	0.5	0.4	0	51.2	52.9	0	146	150	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	13	0	3	31	30.6	-2.5	1.036	0.4	0.3	0	51.2	52.9	0	146	150	0	27	27
2025	10	13	0	13	31	30.6	-0.5	1.036	0.5	0.4	0	50.7	52.9	0	146	150	0	28	27
2025	10	13	0	23	31	31.4	-1.3	1.036	0.5	0.4	0	51.2	52.9	0	146	150	0	27	27
2025	10	13	0	33	31	31	-2.2	1.035	0.5	0.4	0	50.7	52.9	0	146	150	0	28	27
2025	10	13	0	43	31	31.5	-2.5	1.035	0.5	0.4	0	50.7	52.5	0	145	150	0	27	28
2025	10	13	0	53	31	31.4	-1.6	1.035	0.5	0.4	0	51.2	52.9	0	146	150	0	27	27
2025	10	13	1	3	31	31.6	-1.6	1.035	0.5	0.4	0	51.2	52.5	0	146	150	0	27	28
2025	10	13	1	13	31	31.9	-2.5	1.035	0.4	0.3	0	50.3	52	0	145	149	0	28	28
2025	10	13	1	23	31	31.4	-2.4	1.035	0.3	0.2	0	51.2	52.9	0	146	150	0	27	27
2025	10	13	1	33	31	31.4	-2.1	1.035	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	13	1	43	31	30.5	-1.3	1.035	0.5	0.4	0	51.2	52.9	0	146	150	0	27	27
2025	10	13	1	53	31	30.9	-2.8	1.035	0.4	0.3	0	50.3	52.5	0	145	150	0	28	28
2025	10	13	2	3	31	31.4	-0.9	1.035	0.4	0.3	0	50.7	52.5	0	145	149	0	27	27
2025	10	13	2	13	31	31.9	-2	1.035	0.5	0.4	0	50.3	52.5	0	145	149	0	28	27
2025	10	13	2	23	31	29.4	-2.1	1.035	0.4	0.3	0	50.7	52.5	0	145	150	0	27	28
2025	10	13	2	33	31	30.5	-2.5	1.035	0.4	0.3	0	51.2	52.9	0	146	150	0	27	27
2025	10	13	2	43	31	31.3	-1.9	1.035	0.5	0.4	0	50.3	52.9	0	145	150	0	28	27
2025	10	13	2	53	31	30.8	-2.1	1.035	0.3	0.2	0	50.7	52	0	145	149	0	27	28
2025	10	13	3	3	31	30.6	-2.4	1.035	0.5	0.4	0	50.7	52.5	0	146	150	0	28	28
2025	10	13	3	13	31	30.8	-2.5	1.035	0.3	0.2	0	50.7	52	0	145	149	0	27	28
2025	10	13	3	23	31	30.8	-1.9	1.035	0.5	0.4	0	50.7	52.5	0	145	149	0	27	27
2025	10	13	3	33	31	31.9	-1.9	1.035	0.5	0.5	0	50.3	52	0	145	149	0	28	28
2025	10	13	3	43	31	30.9	-1.4	1.035	0.3	0.2	0	50.7	52.9	0	145	150	0	27	27
2025	10	13	3	53	31	31.1	-2	1.035	0.5	0.4	0	50.3	52.5	0	145	149	0	28	27
2025	10	13	4	3	31	30.8	-1.4	1.035	0.3	0.2	0	50.3	52.5	0	145	149	0	28	27
2025	10	13	4	13	31	30.4	-1.4	1.035	0.3	0.2	0	50.7	52.9	0	145	150	0	27	27
2025	10	13	4	23	31	31.2	-1	1.035	0.4	0.3	0	50.7	52	0	145	149	0	27	28
2025	10	13	4	33	31	30.7	-0.9	1.035	0.3	0.2	0	50.3	52	0	145	149	0	28	28
2025	10	13	4	43	31	30.7	-1.7	1.035	0.4	0.3	0	50.7	51.6	0	145	149	0	27	29
2025	10	13	4	53	31	30.3	-2.9	1.035	0.4	0.3	0	50.3	52	0	145	149	0	28	28
2025	10	13	5	3	31	30.7	-2.5	1.035	0.4	0.3	0	49.9	52	0	144	149	0	28	28
2025	10	13	5	13	31	31.5	-2	1.035	0.4	0.3	0	50.3	52	0	144	149	0	27	28
2025	10	13	5	23	31	30.3	-2.3	1.035	0.5	0.4	0	50.3	52	0	144	149	0	27	28
2025	10	13	5	33	31	31.1	-1.5	1.035	0.5	0.5	0	49.9	52	0	144	149	0	28	28
2025	10	13	5	43	31	31.6	-2	1.035	0.4	0.3	0	49.9	52	0	144	148	0	28	27
2025	10	13	5	53	31	30.9	-1.6	1.034	0.4	0.3	0	50.3	52.5	0	144	149	0	27	27
2025	10	13	6	3	31	30.2	-0.8	1.035	0.4	0.3	0	50.3	52	0	144	149	0	27	28
2025	10	13	6	13	31	31.2	-1.6	1.034	0.5	0.4	0	50.3	52.5	0	144	149	0	27	27
2025	10	13	6	23	31	31.6	-1.6	1.034	0.3	0.2	0	49.5	51.6	0	143	148	0	28	28
2025	10	13	6	33	31	30.4	-1.6	1.034	0.4	0.3	0	49.9	51.6	0	143	148	0	27	28
2025	10	13	6	43	31	31	-1.5	1.034	0.3	0.2	0	49.5	52	0	143	148	0	28	27
2025	10	13	6	53	31	30.6	-2.2	1.035	0.4	0.3	0	49.9	52	0	143	148	0	27	27
2025	10	13	7	3	31	32.2	-1	1.035	0.5	0.4	0	49.5	51.2	0	142	147	0	27	28
2025	10	13	7	13	31	31.5	-1.7	1.034	0.5	0.4	0	49	51.2	0	142	147	0	28	28
2025	10	13	7	23	31	29.8	-1	1.034	0.4	0.3	0	49.5	51.2	0	142	146	0	27	27
2025	10	13	7	33	31	30.1	-1.6	1.034	0.4	0.3	0	49	50.7	0	141	146	0	27	28
2025	10	13	7	43	31	31.8	-2.5	1.034	0.4	0.3	0	49	50.7	0	141	146	0	27	28
2025	10	13	7	53	31	30.6	-2.5	1.034	0.4	0.3	0	48.6	50.3	0	141	145	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	13	8	3	31	30.9	-2.3	1.034	0.5	0.4	0	48.6	50.7	0	140	145	0	27	27
2025	10	13	8	13	31	31	-1.4	1.034	0.4	0.3	0	48.2	49.9	0	140	144	0	28	28
2025	10	13	8	23	31	30.5	-0.9	1.034	0.4	0.3	0	48.2	49.9	0	139	144	0	27	28
2025	10	13	8	33	31	31.8	-1.6	1.035	0.4	0.3	0	47.7	49	0	138	142	0	27	28
2025	10	13	8	43	31	31.6	-2	1.035	0.4	0.3	0	47.7	49.5	0	138	142	0	27	27
2025	10	13	8	53	31	30.5	-2	1.035	0.5	0.5	0	47.3	48.6	0	137	141	0	27	28
2025	10	13	9	3	31	30.9	-1.7	1.035	0.4	0.3	0	46.9	48.6	0	136	141	0	27	28
2025	10	13	9	13	31	30.3	-1.8	1.035	0.5	0.4	0	46.4	48.6	0	136	140	0	28	27
2025	10	13	9	23	31	30.7	-1.9	1.035	0.3	0.2	0	46	48.2	0	135	140	0	28	28
2025	10	13	9	33	31	30.5	-2.5	1.035	0.4	0.3	0	46	47.7	0	135	139	0	28	28
2025	10	13	9	43	31	31	-1.6	1.035	0.3	0.2	0	45.6	47.7	0	134	139	0	28	28
2025	10	13	9	53	31	29.9	-1.9	1.035	0.4	0.3	0	45.6	47.3	0	134	138	0	28	28
2025	10	13	10	3	31	29.9	-2	1.035	0.4	0.3	0	46	47.3	0	134	138	0	27	28
2025	10	13	10	13	31	30.8	-2.1	1.035	0.3	0.2	0	45.2	46.9	0	133	137	0	28	28
2025	10	13	10	23	31	31.3	-2.1	1.035	0.4	0.3	0	45.2	47.3	0	133	137	0	28	27
2025	10	13	10	33	31	30.3	-1.3	1.035	0.4	0.3	0	46	47.7	0	134	139	0	27	28
2025	10	13	10	43	31	29.8	-1.7	1.035	0.5	0.4	0	46.4	47.7	0	135	139	0	27	28
2025	10	13	10	53	31	31.3	-2.1	1.035	0.4	0.3	0	45.2	47.7	0	133	138	0	28	27
2025	10	13	11	3	31	30.2	-1.6	1.035	0.3	0.2	0	44.7	46.9	0	132	137	0	28	28
2025	10	13	11	13	31	30.9	-2.4	1.035	0.5	0.4	0	44.7	46.9	0	132	136	0	28	27
2025	10	13	11	23	31	30.2	-1.7	1.035	0.5	0.5	0	44.7	46.9	0	132	137	0	28	28
2025	10	13	11	33	31	30.3	-2.4	1.035	0.4	0.3	0	44.7	46.4	0	132	136	0	28	28
2025	10	13	11	43	31	30.7	-2.9	1.036	0.3	0.2	0	44.3	46.4	0	131	135	0	28	27
2025	10	13	11	53	31	30.6	-3	1.036	0.4	0.3	0	45.2	46	0	132	135	0	27	28
2025	10	13	12	3	31	31.2	-3.1	1.036	0.4	0.3	0	44.7	46.4	0	132	136	0	28	28
2025	10	13	12	13	31	30.5	-2.6	1.036	0.4	0.3	0	45.2	46.9	0	132	136	0	27	27
2025	10	13	12	23	31	29.9	-2	1.036	0.3	0.2	0	45.2	47.3	0	133	138	0	28	28
2025	10	13	12	33	31	30.6	-2.2	1.036	0.3	0.2	0	46	47.7	0	134	138	0	27	27
2025	10	13	12	43	31	32	-2.4	1.036	0.4	0.3	0	46.4	47.7	0	135	139	0	27	28
2025	10	13	12	53	31	30	-3	1.036	0.3	0.2	0	46	47.7	0	134	138	0	27	27
2025	10	13	13	3	31	30.7	-2.3	1.036	0.4	0.3	0	45.2	46.9	0	133	137	0	28	28
2025	10	13	13	13	31	31.4	-1.8	1.036	0.4	0.3	0	45.2	47.3	0	132	137	0	27	27
2025	10	13	13	23	31	31	-2.5	1.036	0.5	0.4	0	45.2	47.3	0	132	137	0	27	27
2025	10	13	13	33	31	30.5	-2.1	1.036	0.5	0.4	0	45.6	47.7	0	133	138	0	27	27
2025	10	13	13	43	31	31.2	-2.5	1.035	0.4	0.3	0	46.9	48.6	0	136	141	0	27	28
2025	10	13	13	53	31	30.5	-2.1	1.037	0.5	0.4	0	49	50.7	0	141	146	0	27	28
2025	10	13	14	3	31	30.4	-1.2	1.036	0.5	0.4	0	50.3	52.5	0	145	149	0	28	27
2025	10	13	14	13	31	31.1	-1.2	1.036	0.5	0.4	0	49.5	52	0	143	148	0	28	27
2025	10	13	14	23	31	31.1	-1.4	1.034	0.4	0.3	0	49	51.2	0	142	147	0	28	28
2025	10	13	14	33	31	30.2	-1.8	1.035	0.4	0.3	0	49.5	51.6	0	142	147	0	27	27
2025	10	13	14	43	31	31.5	-2.5	1.034	0.4	0.3	0	49.5	51.6	0	142	147	0	27	27
2025	10	13	14	53	31	31.5	-1.8	1.035	0.4	0.3	0	48.6	50.3	0	140	145	0	27	28
2025	10	13	15	3	31	30.7	-2.1	1.035	0.5	0.4	0	48.2	49.9	0	139	144	0	27	28
2025	10	13	15	13	31	31.1	-2	1.035	0.4	0.3	0	48.6	50.7	0	140	145	0	27	27
2025	10	13	15	23	31	30.6	-2	1.035	0.4	0.3	0	48.2	50.3	0	140	145	0	28	28
2025	10	13	15	33	31	31.5	-1.9	1.034	0.4	0.3	0	48.6	50.7	0	141	146	0	28	28
2025	10	13	15	43	31	31	-2	1.035	0.5	0.4	0	49	51.6	0	142	147	0	28	27
2025	10	13	15	53	31	31	-2.1	1.035	0.4	0.3	0	48.6	50.7	0	141	146	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	13	16	3	31	31.5	-1.5	1.035	0.5	0.4	0	48.6	51.6	0	141	147	0	28	27
2025	10	13	16	13	31	31.6	-1.9	1.035	0.5	0.4	0	49.9	51.6	0	143	148	0	27	28
2025	10	13	16	23	31	31.7	-1.8	1.035	0.5	0.4	0	48.6	51.2	0	141	146	0	28	27
2025	10	13	16	33	31	31.1	-1.3	1.036	0.4	0.3	0	49	51.2	0	141	146	0	27	27
2025	10	13	16	43	31	31.6	-1.2	1.036	0.3	0.2	0	48.6	50.7	0	140	145	0	27	27
2025	10	13	16	53	31	31	-2	1.034	0.4	0.3	0	48.6	51.2	0	141	146	0	28	27
2025	10	13	17	3	31	31.1	-2.7	1.035	0.5	0.5	0	48.2	50.7	0	140	146	0	28	28
2025	10	13	17	13	31	31.5	-0.7	1.035	0.5	0.4	0	49.9	51.6	0	143	147	0	27	27
2025	10	13	17	23	31	30.4	-1.7	1.036	0.4	0.3	0	49.9	51.6	0	143	147	0	27	27
2025	10	13	17	33	31	31.6	-2.2	1.035	0.4	0.3	0	49.5	51.2	0	142	146	0	27	27
2025	10	13	17	43	31	32	-1.6	1.036	0.5	0.4	0	49.5	51.2	0	142	146	0	27	27
2025	10	13	17	53	31	30.4	-0.8	1.035	0.5	0.4	0	49.5	51.2	0	143	147	0	28	28
2025	10	13	18	3	31	31.6	-2	1.035	0.5	0.5	0	49.9	51.2	0	143	147	0	27	28
2025	10	13	18	13	31	30.7	-1.7	1.036	0.3	0.2	0	50.3	51.6	0	144	148	0	27	28
2025	10	13	18	23	31	31	-1.9	1.035	0.5	0.4	0	50.3	51.6	0	144	148	0	27	28
2025	10	13	18	33	31	30.2	-1.7	1.034	0.5	0.4	0	50.3	51.6	0	144	147	0	27	27
2025	10	13	18	43	31	31.4	-2.5	1.035	0.4	0.3	0	50.3	51.6	0	144	148	0	27	28
2025	10	13	18	53	31	31.5	-2.5	1.035	0.5	0.4	0	49.5	51.6	0	143	147	0	28	27
2025	10	13	19	3	31	31.3	-1.7	1.035	0.4	0.3	0	50.7	52.5	0	145	149	0	27	27
2025	10	13	19	13	31	31.2	-2.1	1.035	0.4	0.3	0	50.3	52.5	0	145	149	0	28	27
2025	10	13	19	23	31	31.4	-1.3	1.035	0.5	0.4	0	51.2	52	0	146	149	0	27	28
2025	10	13	19	33	31	31.2	-1.8	1.034	0.5	0.4	0	50.7	52	0	146	149	0	28	28
2025	10	13	19	43	31	30.6	-1.7	1.035	0.5	0.4	0	51.2	52.5	0	146	149	0	27	27
2025	10	13	19	53	31	31.6	-1.9	1.036	0.4	0.3	0	50.7	52	0	146	149	0	28	28
2025	10	13	20	3	31	31	-2.1	1.036	0.5	0.4	0	50.7	52	0	146	149	0	28	28
2025	10	13	20	13	31	31.5	-1.3	1.035	0.5	0.4	0	50.7	52.5	0	146	149	0	28	27
2025	10	13	20	23	31	31.8	-1.3	1.035	0.4	0.3	0	51.2	52.5	0	146	149	0	27	27
2025	10	13	20	33	31	30.9	-2.5	1.034	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	13	20	43	31	31	-1.8	1.036	0.4	0.3	0	50.7	52.5	0	146	150	0	28	28
2025	10	13	20	53	31	30.5	-1.7	1.035	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	13	21	3	31	31.3	-2.6	1.035	0.5	0.4	0	51.2	52.9	0	147	150	0	28	27
2025	10	13	21	13	31	31.2	-2.1	1.035	0.5	0.4	0	51.2	52.9	0	147	151	0	28	28
2025	10	13	21	23	31	32.1	-1.6	1.035	0.3	0.2	0	50.7	52.5	0	146	150	0	28	28
2025	10	13	21	33	31	30.8	-1.7	1.035	0.5	0.4	0	51.2	52.9	0	146	150	0	27	27
2025	10	13	21	43	31	30.5	-1.8	1.035	0.5	0.4	0	51.6	52.9	0	147	151	0	27	28
2025	10	13	21	53	31	31.7	-3.1	1.035	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	13	22	3	31	31.8	-1.8	1.035	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	13	22	13	31	31.7	-1.3	1.035	0.4	0.3	0	51.2	52.9	0	147	151	0	28	28
2025	10	13	22	23	31	31.6	-2	1.036	0.5	0.4	0	51.2	52.5	0	146	150	0	27	28
2025	10	13	22	33	31	30.8	-2.5	1.035	0.4	0.3	0	50.7	52.5	0	146	150	0	28	28
2025	10	13	22	43	31	31.5	-2.6	1.035	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	13	22	53	31	30.8	-1.2	1.036	0.3	0.2	0	51.6	52.5	0	147	150	0	27	28
2025	10	13	23	3	31	31.6	-1.9	1.036	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	13	23	13	31	31.8	-1.8	1.035	0.5	0.4	0	50.7	52.9	0	146	150	0	28	27
2025	10	13	23	23	31	30.7	-1.7	1.037	0.5	0.4	0	51.2	52.9	0	147	151	0	28	28
2025	10	13	23	33	31	31.6	-2.6	1.036	0.5	0.4	0	50.7	52.5	0	146	150	0	28	28
2025	10	13	23	43	31	32.5	-2	1.036	0.5	0.4	0	51.6	52.5	0	147	150	0	27	28
2025	10	13	23	53	31	30.5	-1.5	1.036	0.3	0.2	0	51.6	53.3	0	147	151	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	14	0	3	31	30.5	-1.5	1.035	0.4	0.3	0	50.7	52.5	0	146	150	0	28	28
2025	10	14	0	13	31	31.4	-2.2	1.034	0.4	0.3	0	50.7	52.9	0	146	150	0	28	27
2025	10	14	0	23	31	31.5	-2.6	1.037	0.3	0.2	0	51.2	52.9	0	146	150	0	27	27
2025	10	14	0	33	31	29.9	-2.4	1.035	0.5	0.4	0	50.7	52.5	0	146	150	0	28	28
2025	10	14	0	43	31	29.8	-2.5	1.036	0.5	0.5	0	51.2	52.9	0	147	151	0	28	28
2025	10	14	0	53	31	31.7	-1.9	1.035	0.5	0.5	0	51.2	52.5	0	146	150	0	27	28
2025	10	14	1	3	31	31.5	-2.3	1.036	0.4	0.3	0	50.7	52.9	0	146	151	0	28	28
2025	10	14	1	13	31	31	-1.5	1.036	0.3	0.2	0	51.2	53.3	0	146	151	0	27	27
2025	10	14	1	23	31	30.9	-0.9	1.036	0.5	0.4	0	51.2	52.9	0	146	151	0	27	28
2025	10	14	1	33	31	31.3	-0.8	1.036	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	14	1	43	31	31.9	-1.1	1.035	0.5	0.4	0	51.2	52.9	0	146	151	0	27	28
2025	10	14	1	53	31	31.2	-1.9	1.036	0.4	0.3	0	50.7	52.5	0	146	150	0	28	28
2025	10	14	2	3	31	31.9	-1.8	1.035	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	14	2	13	31	32.2	-2.8	1.036	0.3	0.2	0	50.7	53.3	0	146	151	0	28	27
2025	10	14	2	23	31	31.2	-2	1.035	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	14	2	33	31	31	-0.8	1.036	0.4	0.3	0	51.2	52.9	0	146	150	0	27	27
2025	10	14	2	43	31	31.1	-2.6	1.035	0.3	0.2	0	51.6	52.9	0	147	151	0	27	28
2025	10	14	2	53	31	31.8	-2	1.036	0.5	0.4	0	51.2	52.5	0	146	150	0	27	28
2025	10	14	3	3	31	29.7	-1.7	1.036	0.5	0.5	0	51.2	53.3	0	146	151	0	27	27
2025	10	14	3	13	31	31	-2.6	1.036	0.4	0.3	0	50.7	52.5	0	146	150	0	28	28
2025	10	14	3	23	31	31.2	-1.7	1.037	0.4	0.3	0	50.7	52.5	0	146	150	0	28	28
2025	10	14	3	33	31	31.2	-2.2	1.036	0.3	0.2	0	51.2	53.3	0	146	151	0	27	27
2025	10	14	3	43	31	31.2	-1	1.037	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	14	3	53	31	31.8	-2.4	1.037	0.5	0.4	0	52.5	52.9	0	150	151	0	28	28
2025	10	14	4	3	31	31.8	-1.3	1.037	0.5	0.4	0	52.5	52.9	0	150	151	0	28	28
2025	10	14	4	13	31	31.2	-1.8	1.037	0.4	0.3	0	53.3	53.3	0	151	151	0	27	27
2025	10	14	4	23	31	30.2	-2	1.037	0.4	0.3	0	52.9	52.5	0	150	150	0	27	28
2025	10	14	4	33	31	30.8	-0.9	1.037	0.4	0.3	0	53.3	52.9	0	151	151	0	27	28
2025	10	14	4	43	31	30.7	-1.8	1.037	0.4	0.3	0	52.9	52.9	0	151	151	0	28	28
2025	10	14	4	53	31	30.3	-1.8	1.036	0.5	0.4	0	52.9	52.9	0	151	151	0	28	28
2025	10	14	5	3	31	30.6	-1.1	1.036	0.5	0.4	0	52.5	53.3	0	150	151	0	28	27
2025	10	14	5	13	31	30.8	-2	1.036	0.5	0.4	0	52.9	53.3	0	151	151	0	28	27
2025	10	14	5	23	31	32.4	-1	1.036	0.4	0.3	0	53.3	52.9	0	151	151	0	27	28
2025	10	14	5	33	31	32	-1.8	1.037	0.3	0.2	0	52.9	52.9	0	150	151	0	27	28
2025	10	14	5	43	31	31.8	-2.8	1.037	0.4	0.3	0	52.9	52.9	0	150	151	0	27	28
2025	10	14	5	53	31	31.1	-2.4	1.037	0.5	0.4	0	53.3	53.3	0	151	151	0	27	27
2025	10	14	6	3	31	31.5	-2.9	1.037	0.4	0.3	0	52.5	52.5	0	150	150	0	28	28
2025	10	14	6	13	31	31.4	-1.6	1.037	0.5	0.4	0	52.9	53.3	0	150	151	0	27	27
2025	10	14	6	23	31	31.5	-1.3	1.037	0.4	0.3	0	53.3	52.9	0	151	151	0	27	28
2025	10	14	6	33	31	31.5	-1.6	1.037	0.4	0.3	0	52.9	52.9	0	151	151	0	28	28
2025	10	14	6	43	31	32.8	-1.9	1.037	0.3	0.2	0	52.5	53.3	0	150	151	0	28	27
2025	10	14	6	53	31	31.1	-2	1.037	0.4	0.3	0	52.5	52.9	0	150	151	0	28	28
2025	10	14	7	3	31	31.8	-2.3	1.037	0.5	0.4	0	52.5	52.9	0	150	151	0	28	28
2025	10	14	7	13	31	31.5	-2.4	1.038	0.4	0.3	0	52.9	52.5	0	150	150	0	27	28
2025	10	14	7	23	31	30.6	-2.9	1.038	0.4	0.3	0	52.9	52.5	0	150	150	0	27	28
2025	10	14	7	33	31	32	-1.3	1.037	0.3	0.2	0	52.9	52.9	0	150	150	0	27	27
2025	10	14	7	43	31	30.8	-1.8	1.037	0.5	0.4	0	52	52.9	0	149	150	0	28	27
2025	10	14	7	53	31	31.7	-2	1.037	0.5	0.4	0	52.5	52	0	149	149	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	14	8	3	31	30.2	-2	1.038	0.4	0.3	0	52	52	0	148	149	0	27	28
2025	10	14	8	13	31	32.2	-2.2	1.038	0.5	0.4	0	51.6	52	0	148	149	0	28	28
2025	10	14	8	23	31	31.5	-3.5	1.039	0.4	0.3	0	51.2	51.6	0	147	148	0	28	28
2025	10	14	8	33	31	31.2	-1.9	1.038	0.4	0.3	0	51.2	51.6	0	147	148	0	28	28
2025	10	14	8	43	31	31.5	-2.4	1.038	0.3	0.2	0	51.2	51.2	0	147	147	0	28	28
2025	10	14	8	53	31	31.5	-1.6	1.038	0.3	0.2	0	51.6	51.2	0	147	147	0	27	28
2025	10	14	9	3	31	30.3	-2.4	1.037	0.5	0.4	0	50.7	51.2	0	146	147	0	28	28
2025	10	14	9	13	31	31.1	-1.5	1.038	0.5	0.4	0	50.7	51.2	0	146	147	0	28	28
2025	10	14	9	23	31	31.8	-2	1.038	0.4	0.3	0	50.3	50.7	0	145	146	0	28	28
2025	10	14	9	33	31	30.9	-1.2	1.038	0.5	0.5	0	50.3	50.7	0	145	146	0	28	28
2025	10	14	9	43	31	31.1	-2.6	1.038	0.4	0.3	0	49.9	50.3	0	144	145	0	28	28
2025	10	14	9	53	31	30.8	-2	1.038	0.3	0.2	0	50.3	51.2	0	145	146	0	28	27
2025	10	14	10	3	31	31.9	-1.4	1.039	0.5	0.4	0	50.3	50.7	0	145	146	0	28	28
2025	10	14	10	13	31	30.7	-1.6	1.039	0.4	0.3	0	50.7	50.7	0	145	146	0	27	28
2025	10	14	10	23	31	31.4	-1.9	1.039	0.5	0.4	0	49.9	50.7	0	144	145	0	28	27
2025	10	14	10	33	31	31.3	-2.4	1.04	0.4	0.3	0	50.3	50.7	0	144	145	0	27	27
2025	10	14	10	43	31	31.7	-3.5	1.04	0.4	0.3	0	50.3	49.9	0	144	144	0	27	28
2025	10	14	10	53	31	30.6	-1.9	1.04	0.5	0.4	0	50.3	50.7	0	144	145	0	27	27
2025	10	14	11	3	31	30.9	-2.2	1.04	0.4	0.3	0	50.3	50.7	0	145	146	0	28	28
2025	10	14	11	13	31	31	-1.8	1.041	0.4	0.3	0	50.3	50.3	0	144	145	0	27	28
2025	10	14	11	23	31	31	-2.3	1.041	0.4	0.3	0	50.3	50.3	0	145	145	0	28	28
2025	10	14	11	33	31	30.8	-2.1	1.041	0.4	0.3	0	49.5	49.9	0	143	144	0	28	28
2025	10	14	11	43	31	31.8	-2.1	1.042	0.4	0.3	0	49	49.9	0	142	144	0	28	28
2025	10	14	11	53	31	31.1	-1.3	1.042	0.5	0.4	0	49	49.5	0	142	143	0	28	28
2025	10	14	12	3	31	31.2	-1.9	1.041	0.5	0.5	0	49.5	49.9	0	142	143	0	27	27
2025	10	14	12	13	31	31.5	-1.2	1.042	0.3	0.2	0	49.5	49.9	0	143	144	0	28	28
2025	10	14	12	23	31	31.7	-1.2	1.043	0.5	0.4	0	49.9	50.3	0	144	145	0	28	28
2025	10	14	12	33	31	30.2	-1.9	1.043	0.6	0.5	0	49.9	50.3	0	144	145	0	28	28
2025	10	14	12	43	31	31.1	-1.3	1.044	0.4	0.3	0	50.3	50.3	0	144	145	0	27	28
2025	10	14	12	53	31	30.7	-1.9	1.044	0.4	0.3	0	50.7	51.2	0	146	147	0	28	28
2025	10	14	13	3	31	32.3	-1.4	1.045	0.3	0.2	0	49.9	51.2	0	144	146	0	28	27
2025	10	14	13	13	31	31.6	-2.1	1.045	0.5	0.5	0	49.9	50.7	0	144	146	0	28	28
2025	10	14	13	23	31	32.1	-1	1.045	0.5	0.5	0	49.5	50.7	0	143	145	0	28	27
2025	10	14	13	33	31	31.5	-0.8	1.045	0.5	0.4	0	49.9	49.9	0	143	144	0	27	28
2025	10	14	13	43	31	32.3	-2.2	1.045	0.5	0.5	0	49.5	49.9	0	142	144	0	27	28
2025	10	14	13	53	31	30.9	-2	1.045	0.5	0.5	0	49.5	49.9	0	143	144	0	28	28
2025	10	14	14	3	31	31.8	-2.8	1.045	0.4	0.3	0	49	50.3	0	142	144	0	28	27
2025	10	14	14	13	31	31.7	-1.7	1.045	0.5	0.4	0	49.5	50.3	0	142	144	0	27	27
2025	10	14	14	23	31	32	-1.4	1.045	0.5	0.5	0	49.5	50.3	0	143	144	0	28	27
2025	10	14	14	33	31	32	-1.4	1.044	0.4	0.3	0	49.9	50.3	0	143	144	0	27	27
2025	10	14	14	43	31	31.4	-1.5	1.045	0.4	0.3	0	49.9	50.7	0	144	146	0	28	28
2025	10	14	14	53	31	32.3	-1.8	1.045	0.4	0.3	0	50.3	51.2	0	145	147	0	28	28
2025	10	14	15	3	31	31.2	-1.7	1.044	0.4	0.3	0	49.9	50.7	0	144	146	0	28	28
2025	10	14	15	13	31	32.3	-1.6	1.046	0.4	0.3	0	50.7	50.7	0	145	146	0	27	28
2025	10	14	15	23	31	31.6	-1.8	1.045	0.5	0.5	0	49.9	50.3	0	144	145	0	28	28
2025	10	14	15	33	31	32.3	-2.4	1.045	0.5	0.4	0	49.5	50.3	0	143	145	0	28	28
2025	10	14	15	43	31	32.4	-1.3	1.046	0.4	0.3	0	49.9	51.2	0	144	146	0	28	27
2025	10	14	15	53	31	31.8	-2.5	1.045	0.4	0.3	0	49.9	50.7	0	144	146	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	14	16	3	31	31.1	-1.3	1.043	0.4	0.3	0	50.7	50.7	0	145	146	0	27	28
2025	10	14	16	13	31	32.7	-1.2	1.045	0.4	0.3	0	49.9	50.7	0	144	146	0	28	28
2025	10	14	16	23	31	31.4	-1.9	1.044	0.3	0.2	0	50.3	51.2	0	145	147	0	28	28
2025	10	14	16	33	31	30.8	-0.7	1.045	0.4	0.3	0	51.6	52	0	147	149	0	27	28
2025	10	14	16	43	31	31.5	-2	1.045	0.5	0.5	0	52	52.5	0	148	149	0	27	27
2025	10	14	16	53	31	31.6	-1.6	1.043	0.5	0.4	0	52	52.5	0	148	150	0	27	28
2025	10	14	17	3	31	32.2	-1.1	1.044	0.4	0.3	0	51.6	52.5	0	148	150	0	28	28
2025	10	14	17	13	31	30.5	-1.2	1.044	0.5	0.4	0	51.6	52	0	147	148	0	27	27
2025	10	14	17	23	31	30.6	-2	1.044	0.4	0.3	0	50.7	51.2	0	146	147	0	28	28
2025	10	14	17	33	31	31.5	-1.6	1.044	0.4	0.3	0	50.7	51.2	0	145	147	0	27	28
2025	10	14	17	43	31	33.1	-3.2	1.044	0.3	0.2	0	49.9	50.7	0	144	146	0	28	28
2025	10	14	17	53	31	30.4	-1.1	1.045	0.4	0.3	0	49.9	50.7	0	144	146	0	28	28
2025	10	14	18	3	31	32.2	-2	1.044	0.5	0.4	0	49.9	50.3	0	144	145	0	28	28
2025	10	14	18	13	31	31.6	-1.2	1.043	0.4	0.3	0	49.5	50.7	0	143	145	0	28	27
2025	10	14	18	23	31	31	-2	1.043	0.5	0.4	0	49.5	50.3	0	143	145	0	28	28
2025	10	14	18	33	31	31.6	-1.3	1.044	0.4	0.3	0	49.5	50.3	0	143	145	0	28	28
2025	10	14	18	43	31	31.3	-1.7	1.044	0.4	0.3	0	49	49.9	0	142	144	0	28	28
2025	10	14	18	53	31	32	-2.9	1.044	0.4	0.3	0	49.9	50.3	0	143	144	0	27	27
2025	10	14	19	3	31	31.2	-2.4	1.045	0.4	0.3	0	49.9	50.3	0	143	145	0	27	28
2025	10	14	19	13	31	31.6	-1.3	1.044	0.5	0.4	0	49.5	50.3	0	143	145	0	28	28
2025	10	14	19	23	31	31.4	-1.6	1.043	0.4	0.3	0	49.5	50.3	0	143	145	0	28	28
2025	10	14	19	33	31	31.2	-2.3	1.044	0.3	0.2	0	49.9	50.7	0	144	146	0	28	28
2025	10	14	19	43	31	31.2	-2.9	1.044	0.5	0.4	0	49.5	50.3	0	143	145	0	28	28
2025	10	14	19	53	31	32.1	-2.7	1.044	0.4	0.3	0	49.5	49.9	0	143	145	0	28	29
2025	10	14	20	3	31	31.8	-2.7	1.044	0.3	0.2	0	49.5	50.7	0	144	146	0	29	28
2025	10	14	20	13	31	31.6	-1.6	1.044	0.5	0.5	0	50.3	50.3	0	144	146	0	27	29
2025	10	14	20	23	31	31.2	-2.3	1.044	0.5	0.4	0	49.5	50.7	0	143	146	0	28	28
2025	10	14	20	33	31	31.2	-2.2	1.044	0.3	0.2	0	50.3	51.2	0	144	146	0	27	27
2025	10	14	20	43	31	31.6	-2.4	1.044	0.4	0.3	0	49.9	50.7	0	144	146	0	28	28
2025	10	14	20	53	31	31.7	-2	1.044	0.4	0.3	0	49.9	50.7	0	144	146	0	28	28
2025	10	14	21	3	31	32.4	-2.1	1.044	0.5	0.5	0	49.9	50.7	0	144	146	0	28	28
2025	10	14	21	13	31	31.1	-1.8	1.044	0.5	0.4	0	50.3	51.2	0	144	147	0	27	28
2025	10	14	21	23	31	30.7	-2	1.044	0.3	0.2	0	50.3	51.2	0	145	147	0	28	28
2025	10	14	21	33	31	31.9	-1	1.044	0.5	0.4	0	49.9	50.7	0	144	147	0	28	29
2025	10	14	21	43	31	30.8	-2	1.044	0.5	0.5	0	50.3	50.7	0	145	147	0	28	29
2025	10	14	21	53	31	31.5	-2.5	1.044	0.4	0.3	0	49.9	51.2	0	144	146	0	28	27
2025	10	14	22	3	31	31.3	-1.6	1.044	0.3	0.2	0	49.9	51.2	0	144	147	0	28	28
2025	10	14	22	13	31	31.4	-1.8	1.043	0.5	0.4	0	49.9	50.7	0	144	146	0	28	28
2025	10	14	22	23	31	30.9	-1.8	1.043	0.5	0.4	0	50.3	51.2	0	145	147	0	28	28
2025	10	14	22	33	31	31.3	-2.7	1.044	0.3	0.2	0	50.3	50.7	0	144	146	0	27	28
2025	10	14	22	43	31	31.4	-2.6	1.044	0.4	0.3	0	49.9	50.3	0	144	146	0	28	29
2025	10	14	22	53	31	30.4	-1.8	1.044	0.5	0.4	0	50.7	51.2	0	145	147	0	27	28
2025	10	14	23	3	31	31.1	-1.3	1.044	0.4	0.3	0	50.3	51.2	0	144	147	0	27	28
2025	10	14	23	13	31	30.3	-2.7	1.044	0.3	0.2	0	50.3	50.7	0	144	146	0	27	28
2025	10	14	23	23	31	31	-1.7	1.044	0.3	0.2	0	50.3	51.2	0	144	147	0	27	28
2025	10	14	23	33	31	31.8	-1.2	1.044	0.3	0.2	0	49.9	50.7	0	144	146	0	28	28
2025	10	14	23	43	31	30.7	-1.2	1.044	0.5	0.4	0	49.9	51.2	0	144	147	0	28	28
2025	10	14	23	53	31	30.8	-2.4	1.044	0.3	0.2	0	49.9	51.2	0	144	146	0	28	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	15	0	3	31	31.3	-3.2	1.044	0.3	0.2	0	49.9	50.7	0	144	146	0	28	28
2025	10	15	0	13	31	30.8	-1.6	1.044	0.5	0.4	0	49.9	51.2	0	144	147	0	28	28
2025	10	15	0	23	31	31.6	-2.2	1.044	0.3	0.2	0	50.3	50.7	0	144	146	0	27	28
2025	10	15	0	33	31	30.9	-1.8	1.044	0.5	0.4	0	49.9	50.7	0	144	146	0	28	28
2025	10	15	0	43	31	30.7	-1.3	1.044	0.4	0.3	0	50.3	50.7	0	144	146	0	27	28
2025	10	15	0	53	31	32.4	-1.7	1.044	0.5	0.4	0	50.3	51.2	0	144	146	0	27	27
2025	10	15	1	3	31	31.8	-2.1	1.044	0.5	0.4	0	49.9	50.7	0	143	146	0	27	28
2025	10	15	1	13	31	31.1	-2	1.044	0.5	0.4	0	49.9	50.7	0	143	146	0	27	28
2025	10	15	1	23	31	32.1	-1.2	1.044	0.3	0.2	0	49.9	50.7	0	143	146	0	27	28
2025	10	15	1	33	31	31.3	-2.4	1.044	0.5	0.4	0	49.5	50.7	0	143	145	0	28	27
2025	10	15	1	43	31	31	-1.5	1.044	0.3	0.2	0	49.5	50.3	0	143	146	0	28	29
2025	10	15	1	53	31	30.5	-2.3	1.044	0.3	0.2	0	49.5	50.3	0	143	145	0	28	28
2025	10	15	2	3	31	32.2	-1.7	1.044	0.5	0.4	0	49.5	50.3	0	143	145	0	28	28
2025	10	15	2	13	31	31.8	-1.8	1.044	0.3	0.2	0	49	50.3	0	142	145	0	28	28
2025	10	15	2	23	31	30.6	-0.9	1.044	0.5	0.5	0	49.5	50.3	0	143	145	0	28	28
2025	10	15	2	33	31	30.6	-1.6	1.044	0.5	0.4	0	49.5	49.9	0	142	145	0	27	29
2025	10	15	2	43	31	32	-1.3	1.044	0.4	0.3	0	49.5	50.3	0	142	145	0	27	28
2025	10	15	2	53	31	31.3	-2.6	1.044	0.4	0.3	0	48.6	49.5	0	141	144	0	28	29
2025	10	15	3	3	31	31.9	-2	1.044	0.4	0.3	0	49	49.5	0	141	144	0	27	29
2025	10	15	3	13	31	32	-1.3	1.045	0.3	0.2	0	48.6	49.9	0	141	144	0	28	28
2025	10	15	3	23	31	31	-1.3	1.045	0.4	0.3	0	48.6	49.9	0	141	144	0	28	28
2025	10	15	3	33	31	31.2	-1.5	1.045	0.3	0.2	0	48.6	49.9	0	141	144	0	28	28
2025	10	15	3	43	31	31.8	-1.6	1.045	0.4	0.3	0	48.2	49.5	0	140	143	0	28	28
2025	10	15	3	53	31	31	-1.6	1.045	0.3	0.2	0	48.6	49.5	0	141	143	0	28	28
2025	10	15	4	3	31	30.4	-1.3	1.045	0.3	0.2	0	48.2	49	0	140	143	0	28	29
2025	10	15	4	13	31	31.3	-1.2	1.045	0.3	0.2	0	48.2	49	0	140	143	0	28	29
2025	10	15	4	23	31	30.5	-1.5	1.046	0.5	0.4	0	47.7	49	0	139	142	0	28	28
2025	10	15	4	33	31	30.9	-1.4	1.046	0.5	0.5	0	47.7	48.6	0	139	142	0	28	29
2025	10	15	4	43	31	31.3	-2.6	1.046	0.4	0.3	0	47.7	48.6	0	139	142	0	28	29
2025	10	15	4	53	31	30.4	-2.1	1.047	0.5	0.4	0	48.2	49	0	139	142	0	27	28
2025	10	15	5	3	31	31.2	-1.6	1.048	0.5	0.4	0	46.9	48.6	0	138	141	0	29	28
2025	10	15	5	13	31	31.2	-1.6	1.048	0.5	0.4	0	47.3	48.2	0	138	141	0	28	29
2025	10	15	5	23	31	30.2	-2	1.049	0.4	0.3	0	47.3	48.2	0	138	141	0	28	29
2025	10	15	5	33	31	31.6	-1.5	1.049	0.4	0.3	0	47.3	48.6	0	137	141	0	27	28
2025	10	15	5	43	31	31.5	-2.6	1.049	0.5	0.4	0	47.3	48.2	0	137	140	0	27	28
2025	10	15	5	53	31	31.5	-1.9	1.049	0.4	0.3	0	46.9	48.2	0	137	140	0	28	28
2025	10	15	6	3	31	32.3	-2.6	1.049	0.5	0.5	0	46.9	48.2	0	137	140	0	28	28
2025	10	15	6	13	31	31.5	-1.1	1.049	0.5	0.4	0	46.9	48.6	0	137	140	0	28	27
2025	10	15	6	23	31	31.6	-1.8	1.049	0.4	0.3	0	46.9	48.6	0	137	140	0	28	27
2025	10	15	6	33	31	30.9	-1.6	1.05	0.5	0.4	0	46.9	47.7	0	137	139	0	28	28
2025	10	15	6	43	31	31.2	-1.9	1.05	0.4	0.3	0	46.4	47.7	0	136	139	0	28	28
2025	10	15	6	53	31	31.8	-2	1.05	0.5	0.4	0	46.4	47.3	0	136	139	0	28	29
2025	10	15	7	3	31	31.8	-2.4	1.05	0.4	0.3	0	46.4	47.7	0	136	139	0	28	28
2025	10	15	7	13	31	31	-1.8	1.05	0.3	0.2	0	46.4	47.3	0	135	138	0	27	28
2025	10	15	7	23	31	32.2	-2	1.05	0.4	0.3	0	46	47.3	0	135	138	0	28	28
2025	10	15	7	33	31	32.2	-1.4	1.05	0.5	0.4	0	45.6	46.4	0	134	137	0	28	29
2025	10	15	7	43	31	32.3	-1.9	1.05	0.3	0.2	0	45.6	46.9	0	134	137	0	28	28
2025	10	15	7	53	31	31.4	-2.3	1.05	0.3	0.2	0	45.6	46.4	0	133	136	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	15	8	3	31	32.8	-2.5	1.05	0.4	0.3	0	45.2	46	0	133	136	0	28	29
2025	10	15	8	13	31	32.5	-1.9	1.05	0.5	0.4	0	45.2	46.4	0	133	136	0	28	28
2025	10	15	8	23	31	30.8	-1.6	1.051	0.5	0.4	0	45.2	46.4	0	133	136	0	28	28
2025	10	15	8	40	0	32	-2.7	1.051	0.4	0.3	0	44.7	45.6	0	132	135	0	28	29
2025	10	15	8	50	0	31.2	-1.6	1.051	0.3	0.2	0	44.7	46	0	132	135	0	28	28
2025	10	15	9	0	0	31	-2.3	1.051	0.3	0.2	0	44.7	46.4	0	132	135	0	28	27
2025	10	15	9	10	0	32.9	-3.1	1.051	0.4	0.3	0	44.7	45.6	0	131	134	0	27	28
2025	10	15	9	20	0	31	-2.1	1.051	0.4	0.3	0	44.3	45.6	0	131	134	0	28	28
2025	10	15	9	30	0	31	-1.9	1.051	0.3	0.2	0	43.4	45.6	0	130	134	0	29	28
2025	10	15	9	40	0	31.9	-0.8	1.051	0.4	0.3	0	43.9	45.2	0	130	133	0	28	28
2025	10	15	9	50	0	31.8	-1.9	1.051	0.4	0.3	0	44.7	45.6	0	132	135	0	28	29
2025	10	15	10	0	0	30.2	-1.2	1.051	0.3	0.2	0	44.3	45.2	0	131	134	0	28	29
2025	10	15	10	10	0	30.8	-2.1	1.052	0.5	0.4	0	44.3	45.6	0	131	134	0	28	28
2025	10	15	10	20	0	31.8	-0.8	1.052	0.4	0.3	0	43.9	44.7	0	130	133	0	28	29
2025	10	15	10	30	0	31.1	-1.8	1.052	0.5	0.4	0	44.7	44.7	0	131	133	0	27	29
2025	10	15	10	40	0	31.8	-1.5	1.052	0.4	0.3	0	43.9	44.7	0	130	133	0	28	29
2025	10	15	10	50	0	30.9	-1.9	1.052	0.4	0.3	0	43.9	45.2	0	130	133	0	28	28
2025	10	15	11	0	0	32	-3.3	1.052	0.3	0.2	0	44.3	44.7	0	130	132	0	27	28
2025	10	15	11	10	0	32.5	-1.1	1.052	0.4	0.3	0	43.9	45.2	0	130	133	0	28	28
2025	10	15	11	20	0	32.4	-1.8	1.052	0.5	0.4	0	43.9	45.2	0	130	133	0	28	28
2025	10	15	11	30	0	30.9	-2	1.052	0.5	0.5	0	43.4	45.2	0	130	133	0	29	28
2025	10	15	11	40	0	30.8	-1.8	1.053	0.4	0.3	0	43.4	44.7	0	129	132	0	28	28
2025	10	15	11	50	0	31.3	-2.1	1.053	0.5	0.4	0	43.9	45.2	0	130	133	0	28	28
2025	10	15	12	0	0	31.6	-1.9	1.053	0.4	0.3	0	43.9	44.7	0	130	133	0	28	29
2025	10	15	12	10	0	30.8	-1.3	1.053	0.4	0.3	0	43.9	45.2	0	130	133	0	28	28
2025	10	15	12	20	0	31.2	-2	1.053	0.4	0.3	0	44.3	45.2	0	130	133	0	27	28
2025	10	15	12	30	0	31.2	-1	1.053	0.4	0.3	0	44.3	45.6	0	131	134	0	28	28
2025	10	15	12	40	0	31.2	-1.8	1.053	0.5	0.5	0	44.3	45.6	0	131	134	0	28	28
2025	10	15	12	50	0	31.7	-2.6	1.054	0.5	0.4	0	44.3	44.7	0	131	133	0	28	29
2025	10	15	13	0	0	30.9	-1.6	1.054	0.5	0.4	0	43.9	45.2	0	131	133	0	29	28
2025	10	15	13	10	0	31.9	-1.7	1.054	0.5	0.4	0	43.9	44.7	0	130	133	0	28	29
2025	10	15	13	20	0	31.5	-1.8	1.054	0.5	0.4	0	44.3	45.6	0	131	134	0	28	28
2025	10	15	13	30	0	31.7	-2.1	1.054	0.5	0.4	0	44.7	45.6	0	132	134	0	28	28
2025	10	15	13	40	0	31.1	-1.4	1.054	0.3	0.2	0	44.7	46	0	132	135	0	28	28
2025	10	15	13	50	0	31.8	-1.9	1.054	0.4	0.3	0	45.2	46	0	133	135	0	28	28
2025	10	15	14	0	0	31.8	-1.4	1.055	0.3	0.2	0	45.2	45.6	0	132	134	0	27	28
2025	10	15	14	10	0	32.1	-1.7	1.055	0.5	0.4	0	44.7	45.2	0	131	134	0	27	29
2025	10	15	14	20	0	31.2	-1.5	1.055	0.5	0.4	0	44.7	45.6	0	132	134	0	28	28
2025	10	15	14	30	0	31.7	-2.9	1.055	0.4	0.3	0	45.2	45.6	0	132	134	0	27	28
2025	10	15	14	40	0	31.5	-1.4	1.055	0.5	0.4	0	44.7	45.6	0	132	134	0	28	28
2025	10	15	14	50	0	30.9	-2	1.055	0.5	0.4	0	45.2	46	0	132	135	0	27	28
2025	10	15	15	0	0	30.8	-2.2	1.055	0.3	0.2	0	45.2	45.6	0	132	134	0	27	28
2025	10	15	15	10	0	31.6	-1.7	1.055	0.4	0.3	0	45.2	46	0	132	135	0	27	28
2025	10	15	15	20	0	31.9	-2.6	1.055	0.4	0.3	0	44.3	45.6	0	131	134	0	28	28
2025	10	15	15	30	0	32.8	-2.2	1.056	0.5	0.4	0	44.7	46	0	131	134	0	27	27
2025	10	15	15	40	0	31.3	-1.2	1.056	0.4	0.3	0	44.3	45.6	0	131	134	0	28	28
2025	10	15	15	50	0	32.5	-1.5	1.056	0.4	0.3	0	44.7	46	0	132	135	0	28	28
2025	10	15	16	0	0	32.5	-2.4	1.056	0.3	0.2	0	45.6	46.4	0	133	136	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	15	16	10	0	32.4	-1.2	1.056	0.4	0.3	0	45.2	46.4	0	133	136	0	28	28
2025	10	15	16	20	0	32.1	-1.9	1.056	0.5	0.4	0	46	46.4	0	134	136	0	27	28
2025	10	15	16	30	0	31.9	-1.8	1.056	0.3	0.2	0	45.6	46.4	0	134	136	0	28	28
2025	10	15	16	40	0	31.7	-2	1.056	0.5	0.4	0	45.6	46.4	0	134	136	0	28	28
2025	10	15	16	50	0	32	-1.9	1.056	0.3	0.2	0	45.2	47.3	0	133	137	0	28	27
2025	10	15	17	0	0	30.7	-1.2	1.056	0.4	0.3	0	45.6	46.9	0	134	137	0	28	28
2025	10	15	17	10	0	31.8	-2.2	1.056	0.4	0.3	0	46	46.9	0	134	137	0	27	28
2025	10	15	17	20	0	32.8	-1.7	1.056	0.5	0.4	0	46	46.9	0	134	137	0	27	28
2025	10	15	17	30	0	31.4	-1.8	1.056	0.4	0.3	0	45.6	47.3	0	134	138	0	28	28
2025	10	15	17	40	0	31.9	-1.6	1.056	0.4	0.3	0	46.4	47.3	0	135	138	0	27	28
2025	10	15	17	50	0	32.7	-2.3	1.057	0.4	0.3	0	46.4	47.3	0	135	138	0	27	28
2025	10	15	18	0	0	31.8	-2.7	1.057	0.3	0.2	0	46	47.7	0	135	138	0	28	27
2025	10	15	18	10	0	32.4	-2.8	1.057	0.4	0.3	0	46.4	47.3	0	136	138	0	28	28
2025	10	15	18	20	0	32.2	-1.6	1.057	0.4	0.3	0	47.3	47.7	0	137	139	0	27	28
2025	10	15	18	30	0	31.7	-2	1.057	0.4	0.3	0	46.9	47.7	0	137	140	0	28	29
2025	10	15	18	40	0	31.3	-1.5	1.057	0.4	0.3	0	47.7	48.6	0	138	141	0	27	28
2025	10	15	18	50	0	32.8	-1.4	1.057	0.3	0.2	0	47.7	48.6	0	139	141	0	28	28
2025	10	15	19	0	0	32.1	-1.6	1.057	0.4	0.3	0	48.2	49.5	0	139	143	0	27	28
2025	10	15	19	10	0	32.4	-1.3	1.057	0.3	0.2	0	48.2	49.5	0	140	143	0	28	28
2025	10	15	19	20	0	32.6	-2.4	1.057	0.4	0.3	0	48.2	49.5	0	140	143	0	28	28
2025	10	15	19	30	0	31.3	-1.2	1.057	0.3	0.2	0	48.6	49.9	0	141	144	0	28	28
2025	10	15	19	40	0	31.3	-1.2	1.057	0.4	0.3	0	48.6	50.3	0	141	145	0	28	28
2025	10	15	19	50	0	33.6	-2	1.057	0.4	0.3	0	49	49.9	0	141	144	0	27	28
2025	10	15	20	0	0	31.6	-1.6	1.057	0.3	0.2	0	49	49.9	0	141	144	0	27	28
2025	10	15	20	10	0	31.2	-2.2	1.057	0.4	0.3	0	49	50.3	0	142	145	0	28	28
2025	10	15	20	20	0	32.6	-2.7	1.057	0.3	0.2	0	49	50.3	0	142	145	0	28	28
2025	10	15	20	30	0	32.1	-1.9	1.057	0.4	0.3	0	49.5	50.3	0	142	145	0	27	28
2025	10	15	20	40	0	32	-1.5	1.058	0.5	0.5	0	49	50.3	0	142	145	0	28	28
2025	10	15	20	50	0	31.1	-2.4	1.058	0.5	0.4	0	49.5	50.7	0	143	146	0	28	28
2025	10	15	21	0	0	32.7	-2.4	1.058	0.5	0.4	0	49.5	50.7	0	143	146	0	28	28
2025	10	15	21	10	0	31.5	-2	1.058	0.5	0.4	0	49.5	51.2	0	143	146	0	28	27
2025	10	15	21	20	0	32.5	-2.6	1.058	0.4	0.3	0	49.9	50.7	0	143	146	0	27	28
2025	10	15	21	30	0	32.6	-3.7	1.058	0.4	0.3	0	49.9	50.3	0	143	146	0	27	29
2025	10	15	21	40	0	32.2	-2	1.058	0.5	0.4	0	49.9	51.2	0	144	147	0	28	28
2025	10	15	21	50	0	32.2	-1.3	1.058	0.4	0.3	0	49.9	51.2	0	144	147	0	28	28
2025	10	15	22	0	0	31.8	-1.6	1.059	0.3	0.2	0	49.9	51.2	0	144	147	0	28	28
2025	10	15	22	10	0	31.7	-1.1	1.06	0.3	0.2	0	49.9	51.2	0	144	147	0	28	28
2025	10	15	22	20	0	32.2	-2.6	1.06	0.4	0.3	0	50.3	51.2	0	144	147	0	27	28
2025	10	15	22	30	0	31.2	-2	1.061	0.5	0.4	0	50.3	51.6	0	145	148	0	28	28
2025	10	15	22	40	0	32.2	-1.8	1.062	0.3	0.2	0	49.9	51.6	0	144	148	0	28	28
2025	10	15	22	50	0	32.1	-1.1	1.062	0.5	0.5	0	50.3	51.6	0	145	148	0	28	28
2025	10	15	23	0	0	31.3	-2.1	1.062	0.3	0.2	0	50.3	51.6	0	145	148	0	28	28
2025	10	15	23	10	0	31.7	-2	1.062	0.3	0.2	0	50.7	51.6	0	145	148	0	27	28
2025	10	15	23	20	0	32.6	-2.3	1.062	0.3	0.2	0	50.3	51.6	0	145	148	0	28	28
2025	10	15	23	30	0	32.4	-1.6	1.063	0.3	0.2	0	50.3	52	0	145	148	0	28	27
2025	10	15	23	40	0	32.6	-2.9	1.063	0.4	0.3	0	50.7	51.6	0	145	148	0	27	28
2025	10	15	23	50	0	32.2	-2.2	1.063	0.4	0.3	0	50.3	51.6	0	145	148	0	28	28
2025	10	16	0	0	0	33.1	-1.6	1.063	0.3	0.2	0	50.3	51.6	0	145	148	0	28	28

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	16	0	10	0	33.5	-0.6	1.063	0.4	0.3	0	50.3	51.6	0	145	148	0	28	28
2025	10	16	0	20	0	32.7	-3	1.063	0.5	0.4	0	50.3	51.6	0	145	148	0	28	28
2025	10	16	0	30	0	31.9	-2.2	1.063	0.4	0.3	0	50.7	52	0	145	148	0	27	27
2025	10	16	0	40	0	32	-1.7	1.063	0.3	0.2	0	50.7	51.6	0	145	148	0	27	28
2025	10	16	0	50	0	32.6	-2.1	1.063	0.5	0.4	0	49.9	51.6	0	145	148	0	29	28
2025	10	16	1	0	0	32.4	-2.1	1.063	0.5	0.4	0	49.9	51.6	0	144	148	0	28	28
2025	10	16	1	10	0	31.8	-2.3	1.063	0.3	0.2	0	49.9	51.6	0	144	148	0	28	28
2025	10	16	1	20	0	31.7	-2	1.063	0.4	0.3	0	49.9	51.6	0	144	148	0	28	28
2025	10	16	1	30	0	32.6	-2.1	1.063	0.4	0.3	0	50.3	51.6	0	145	148	0	28	28
2025	10	16	1	40	0	31.3	-1.6	1.063	0.4	0.3	0	49.9	51.2	0	144	148	0	28	29
2025	10	16	1	50	0	32.1	-2	1.063	0.4	0.3	0	49.9	51.6	0	144	148	0	28	28
2025	10	16	2	0	0	32.1	-2	1.063	0.3	0.2	0	49.9	51.6	0	144	148	0	28	28
2025	10	16	2	10	0	32.7	-1	1.063	0.5	0.4	0	49.9	51.6	0	144	148	0	28	28
2025	10	16	2	20	0	32.5	-1.2	1.063	0.4	0.3	0	49.9	51.6	0	144	148	0	28	28
2025	10	16	2	30	0	32.2	-1.5	1.063	0.3	0.2	0	50.3	51.2	0	144	147	0	27	28
2025	10	16	2	40	0	32.4	-2	1.062	0.5	0.4	0	49.9	51.6	0	144	148	0	28	28
2025	10	16	2	50	0	33	-1.5	1.063	0.3	0.2	0	50.3	51.2	0	144	147	0	27	28
2025	10	16	3	0	0	32.1	-2.4	1.062	0.3	0.2	0	49.9	51.2	0	144	147	0	28	28
2025	10	16	3	10	0	32.7	-2.9	1.062	0.4	0.3	0	49.5	51.2	0	143	147	0	28	28
2025	10	16	3	20	0	32.2	-2.6	1.062	0.3	0.2	0	49.5	51.2	0	143	147	0	28	28
2025	10	16	3	30	0	31.8	-1.1	1.062	0.4	0.3	0	49.5	51.2	0	143	147	0	28	28
2025	10	16	3	40	0	32.7	-2	1.062	0.5	0.4	0	49.9	51.2	0	144	147	0	28	28
2025	10	16	3	50	0	32.3	-2	1.062	0.5	0.4	0	49.5	51.2	0	143	147	0	28	28
2025	10	16	4	0	0	32.5	-2.6	1.062	0.4	0.3	0	49.9	50.7	0	143	147	0	27	29
2025	10	16	4	10	0	31.5	-2.8	1.062	0.4	0.3	0	49.9	50.7	0	144	147	0	28	29
2025	10	16	4	20	0	31.8	-2.4	1.062	0.4	0.3	0	49.5	51.2	0	143	147	0	28	28
2025	10	16	4	30	0	32.4	-1.3	1.062	0.5	0.4	0	49.5	51.2	0	143	147	0	28	28
2025	10	16	4	40	0	32.1	-1.5	1.062	0.4	0.3	0	49.5	50.7	0	143	147	0	28	29
2025	10	16	4	50	0	32.9	-2.6	1.061	0.4	0.3	0	49.5	50.7	0	143	147	0	28	29
2025	10	16	5	0	0	32.5	-1.9	1.061	0.5	0.4	0	49.5	51.2	0	143	147	0	28	28
2025	10	16	5	10	0	32.9	-2	1.061	0.4	0.3	0	49.5	51.2	0	143	147	0	28	28
2025	10	16	5	20	0	32.5	-2	1.061	0.3	0.2	0	49.5	51.2	0	143	147	0	28	28
2025	10	16	5	30	0	32	-2.4	1.061	0.3	0.2	0	49.5	50.7	0	143	146	0	28	28
2025	10	16	5	40	0	32.2	-2.1	1.061	0.5	0.4	0	49.5	50.7	0	143	146	0	28	28
2025	10	16	5	50	0	32.5	-1.3	1.061	0.4	0.3	0	49.5	50.7	0	143	146	0	28	28
2025	10	16	6	0	0	32	-1.6	1.061	0.4	0.3	0	49.5	50.7	0	142	146	0	27	28
2025	10	16	6	10	0	32.2	-1.3	1.061	0.3	0.2	0	49	50.3	0	142	146	0	28	29
2025	10	16	6	20	0	32.3	-2.2	1.06	0.4	0.3	0	49	50.7	0	142	146	0	28	28
2025	10	16	6	30	0	32	-2.3	1.06	0.3	0.2	0	49	50.7	0	142	146	0	28	28
2025	10	16	6	40	0	32.6	-2	1.06	0.3	0.2	0	49	50.7	0	142	146	0	28	28
2025	10	16	6	50	0	32.6	-2.8	1.06	0.4	0.3	0	49	50.3	0	142	145	0	28	28
2025	10	16	7	0	0	33.1	-2.3	1.06	0.5	0.4	0	49	50.3	0	142	145	0	28	28
2025	10	16	7	10	0	32.1	-0.8	1.059	0.3	0.2	0	49	49.9	0	142	145	0	28	29
2025	10	16	7	20	0	32.4	-1.6	1.059	0.5	0.4	0	48.6	50.3	0	141	145	0	28	28
2025	10	16	7	30	0	33.3	-1.8	1.059	0.5	0.4	0	48.6	49.5	0	141	144	0	28	29
2025	10	16	7	40	0	32	-3.1	1.059	0.3	0.2	0	47.7	49.9	0	140	144	0	29	28
2025	10	16	7	50	0	32.4	-2.3	1.059	0.3	0.2	0	48.2	49.5	0	140	143	0	28	28
2025	10	16	8	0	0	31.7	-1.9	1.059	0.4	0.3	0	48.2	49.9	0	140	144	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	16	8	10	0	31.6	-1.8	1.058	0.5	0.5	0	47.7	49.5	0	139	143	0	28	28
2025	10	16	8	20	0	32	-2.1	1.058	0.4	0.3	0	47.7	48.6	0	139	142	0	28	29
2025	10	16	8	30	0	31.2	-2	1.058	0.3	0.2	0	47.3	49	0	138	142	0	28	28
2025	10	16	8	40	0	32.3	-1.9	1.057	0.3	0.2	0	47.3	48.6	0	138	141	0	28	28
2025	10	16	8	50	0	32.4	-2.3	1.057	0.4	0.3	0	46.9	48.2	0	137	141	0	28	29
2025	10	16	9	0	0	32.4	-1.9	1.057	0.4	0.3	0	46.9	48.6	0	137	141	0	28	28
2025	10	16	9	10	0	32.8	-1.2	1.056	0.3	0.2	0	46.9	48.6	0	137	141	0	28	28
2025	10	16	9	20	0	32.1	-1.9	1.055	0.3	0.2	0	46	47.7	0	136	140	0	29	29
2025	10	16	9	30	0	31.8	-2.7	1.054	0.5	0.4	0	46.4	47.7	0	136	140	0	28	29
2025	10	16	9	40	0	32.8	-1.4	1.054	0.3	0.2	0	46.4	48.2	0	136	140	0	28	28
2025	10	16	9	50	0	31.3	-2.2	1.054	0.4	0.3	0	46	48.2	0	136	140	0	29	28
2025	10	16	10	0	0	31.8	-3.1	1.054	0.5	0.4	0	46.4	47.3	0	136	139	0	28	29
2025	10	16	10	10	0	31.3	-1.4	1.053	0.3	0.2	0	46	47.3	0	135	139	0	28	29
2025	10	16	10	20	0	31.3	-1.9	1.053	0.3	0.2	0	45.6	46.9	0	134	138	0	28	29
2025	10	16	10	30	0	30.3	-1.5	1.053	0.5	0.4	0	45.6	46.9	0	134	138	0	28	29
2025	10	16	10	40	0	31.7	-1.9	1.053	0.4	0.3	0	45.6	46.9	0	134	138	0	28	29
2025	10	16	10	50	0	31.2	-1.6	1.053	0.4	0.3	0	45.6	47.3	0	134	138	0	28	28
2025	10	16	11	0	0	31.2	-2.2	1.053	0.3	0.2	0	45.2	46.9	0	134	137	0	29	28
2025	10	16	11	10	0	31.3	-1	1.053	0.4	0.3	0	45.6	47.3	0	134	138	0	28	28
2025	10	16	11	20	0	30.5	-1	1.053	0.4	0.3	0	46	47.7	0	135	139	0	28	28
2025	10	16	11	30	0	30.8	-1.8	1.052	0.4	0.3	0	46.4	48.2	0	136	140	0	28	28
2025	10	16	11	40	0	30.8	-1.8	1.053	0.4	0.3	0	46	47.7	0	135	140	0	28	29
2025	10	16	11	50	0	30.8	-1.6	1.052	0.3	0.2	0	46	47.7	0	135	139	0	28	28
2025	10	16	12	0	0	30	-1.6	1.052	0.4	0.3	0	46.4	47.3	0	135	138	0	27	28
2025	10	16	12	10	0	31.9	-2.8	1.052	0.4	0.3	0	45.6	46.9	0	134	138	0	28	29
2025	10	16	12	20	0	31.3	-2.1	1.052	0.4	0.3	0	45.6	47.7	0	134	139	0	28	28
2025	10	16	12	30	0	31.4	-2	1.052	0.4	0.3	0	46	47.7	0	135	139	0	28	28
2025	10	16	12	40	0	30.5	-0.8	1.052	0.5	0.4	0	46.9	48.2	0	136	140	0	27	28
2025	10	16	12	50	0	30.3	-1.4	1.051	0.5	0.4	0	46	47.7	0	135	139	0	28	28
2025	10	16	13	0	0	32.3	-1.5	1.051	0.5	0.4	0	46	48.2	0	135	139	0	28	27
2025	10	16	13	10	0	30.9	-0.8	1.051	0.4	0.3	0	46.9	48.2	0	136	140	0	27	28
2025	10	16	13	20	0	31.1	-1.8	1.051	0.3	0.2	0	46.4	48.2	0	136	140	0	28	28
2025	10	16	13	30	0	32	-1.8	1.05	0.5	0.4	0	45.6	47.3	0	134	138	0	28	28
2025	10	16	13	40	0	30.9	-1.3	1.05	0.3	0.2	0	46	47.7	0	135	139	0	28	28
2025	10	16	13	50	0	30.3	-1.9	1.048	0.4	0.3	0	46	46.9	0	135	138	0	28	29
2025	10	16	14	0	0	29.9	-1.4	1.047	0.5	0.4	0	46	47.7	0	135	139	0	28	28
2025	10	16	14	10	0	31.6	-1.9	1.047	0.4	0.3	0	46	47.3	0	135	139	0	28	29
2025	10	16	14	20	0	31.7	-1.6	1.047	0.3	0.2	0	46	47.7	0	135	139	0	28	28
2025	10	16	14	30	0	30.9	-1.8	1.047	0.5	0.4	0	46.4	47.7	0	135	139	0	27	28
2025	10	16	14	40	0	31.6	-1.9	1.046	0.4	0.3	0	46.4	47.7	0	135	139	0	27	28
2025	10	16	14	50	0	31	-0.9	1.046	0.4	0.3	0	46.4	47.7	0	136	139	0	28	28
2025	10	16	15	0	0	31.1	-1	1.046	0.5	0.4	0	46.9	48.2	0	136	140	0	27	28
2025	10	16	15	10	0	30.9	-2.1	1.046	0.3	0.2	0	46.4	48.2	0	136	140	0	28	28
2025	10	16	15	20	0	31.3	-2	1.046	0.4	0.3	0	46.4	48.6	0	136	141	0	28	28
2025	10	16	15	30	0	31	-2	1.046	0.4	0.3	0	47.3	49	0	137	141	0	27	27
2025	10	16	15	40	0	31.1	-2.3	1.046	0.4	0.3	0	47.3	49	0	137	142	0	27	28
2025	10	16	15	50	0	31.3	-1.5	1.045	0.5	0.4	0	47.3	49	0	137	142	0	27	28
2025	10	16	16	0	0	30.8	-1.3	1.045	0.5	0.4	0	47.3	49	0	138	142	0	28	28

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	16	16	10	0	30.9	-1.3	1.045	0.5	0.4	0	48.2	49	0	139	143	0	27	29
2025	10	16	16	20	0	31.3	-1.6	1.045	0.4	0.3	0	47.7	49.5	0	139	143	0	28	28
2025	10	16	16	30	0	30.6	-2.5	1.045	0.5	0.4	0	48.2	49.5	0	139	143	0	27	28
2025	10	16	16	40	0	31.1	-1.6	1.045	0.4	0.3	0	48.6	50.3	0	140	144	0	27	27
2025	10	16	16	50	0	32	-1.1	1.045	0.3	0.2	0	48.6	49.9	0	140	144	0	27	28
2025	10	16	17	0	0	31.6	-1.6	1.045	0.4	0.3	0	49	50.3	0	141	145	0	27	28
2025	10	16	17	10	0	30.9	-2.4	1.045	0.5	0.4	0	48.6	50.7	0	141	145	0	28	27
2025	10	16	17	20	0	31.2	-2	1.045	0.3	0.2	0	49.5	50.7	0	142	146	0	27	28
2025	10	16	17	30	0	30.3	-1.8	1.044	0.3	0.2	0	48.6	50.3	0	141	145	0	28	28
2025	10	16	17	40	0	31.4	-1.9	1.044	0.5	0.5	0	48.2	50.3	0	141	145	0	29	28
2025	10	16	17	50	0	31	-1.7	1.044	0.3	0.2	0	48.6	50.3	0	141	145	0	28	28
2025	10	16	18	0	0	30.8	-2	1.044	0.5	0.4	0	48.6	50.7	0	141	146	0	28	28
2025	10	16	18	10	0	30.4	-1.9	1.044	0.5	0.4	0	49.5	50.7	0	142	146	0	27	28
2025	10	16	18	20	0	31.2	-1.6	1.044	0.5	0.5	0	49	50.7	0	142	146	0	28	28
2025	10	16	18	30	0	31.3	-1.8	1.044	0.3	0.2	0	49	50.7	0	142	146	0	28	28
2025	10	16	18	40	0	31.4	-1.6	1.043	0.4	0.3	0	49	50.7	0	142	146	0	28	28
2025	10	16	18	50	0	32	-2.5	1.044	0.4	0.3	0	49	51.2	0	142	147	0	28	28
2025	10	16	19	0	0	30	-2	1.043	0.3	0.2	0	49.5	51.2	0	143	147	0	28	28
2025	10	16	19	10	0	31.4	-1.5	1.043	0.5	0.4	0	49.9	51.2	0	143	147	0	27	28
2025	10	16	19	20	0	30.1	-2.1	1.043	0.4	0.3	0	49.5	51.2	0	143	147	0	28	28
2025	10	16	19	30	0	31.4	-0.8	1.043	0.3	0.2	0	49.9	51.6	0	144	148	0	28	28
2025	10	16	19	40	0	31	-2	1.043	0.4	0.3	0	49.9	51.6	0	144	148	0	28	28
2025	10	16	19	50	0	32.1	-2.4	1.043	0.3	0.2	0	49.9	51.6	0	144	148	0	28	28
2025	10	16	20	0	0	31.7	-2.4	1.043	0.3	0.2	0	49.9	51.6	0	144	148	0	28	28
2025	10	16	20	10	0	31.2	-1.6	1.043	0.5	0.4	0	50.7	52	0	145	149	0	27	28
2025	10	16	20	20	0	31.5	-1.7	1.043	0.5	0.5	0	50.3	52	0	145	149	0	28	28
2025	10	16	20	30	0	31.3	-2.2	1.043	0.3	0.2	0	49.9	52	0	144	149	0	28	28
2025	10	16	20	40	0	30.2	-0.4	1.043	0.5	0.4	0	50.3	52.5	0	145	149	0	28	27
2025	10	16	20	50	0	30.9	-1.6	1.043	0.4	0.3	0	49.9	52	0	144	149	0	28	28
2025	10	16	21	0	0	30.6	-1.2	1.042	0.5	0.4	0	50.7	52	0	145	149	0	27	28
2025	10	16	21	10	0	30.9	-1	1.042	0.4	0.3	0	50.7	52	0	145	149	0	27	28
2025	10	16	21	20	0	31.3	-1.2	1.042	0.3	0.2	0	50.3	52	0	145	149	0	28	28
2025	10	16	21	30	0	30.7	-1.7	1.042	0.5	0.4	0	50.7	52	0	145	149	0	27	28
2025	10	16	21	40	0	31.5	-1.7	1.042	0.4	0.3	0	50.3	52.5	0	145	150	0	28	28
2025	10	16	21	50	0	31.7	-2	1.042	0.3	0.2	0	50.3	52.5	0	145	150	0	28	28
2025	10	16	22	0	0	31.6	-2	1.042	0.3	0.2	0	50.3	52.5	0	145	150	0	28	28
2025	10	16	22	10	0	31	-2.2	1.042	0.4	0.3	0	50.3	52.5	0	145	150	0	28	28
2025	10	16	22	20	0	31.1	-2.3	1.042	0.4	0.3	0	50.3	52	0	145	149	0	28	28
2025	10	16	22	30	0	32	-2.8	1.042	0.4	0.3	0	50.3	52.5	0	145	150	0	28	28
2025	10	16	22	40	0	31.2	-1.2	1.041	0.4	0.3	0	50.3	52.5	0	145	150	0	28	28
2025	10	16	22	50	0	32	-1.8	1.041	0.3	0.2	0	50.3	52.5	0	145	150	0	28	28
2025	10	16	23	0	0	31	-2.8	1.041	0.5	0.4	0	50.3	52.5	0	145	150	0	28	28
2025	10	16	23	10	0	30.4	-1.3	1.041	0.3	0.2	0	50.7	52.5	0	146	150	0	28	28
2025	10	16	23	20	0	30	-1.9	1.041	0.5	0.4	0	50.3	52.5	0	145	150	0	28	28
2025	10	16	23	30	0	32	-2.2	1.041	0.5	0.5	0	49.9	52.5	0	145	150	0	29	28
2025	10	16	23	40	0	31.5	-1.9	1.041	0.4	0.3	0	50.3	52.5	0	145	150	0	28	28
2025	10	16	23	50	0	31.3	-1.6	1.041	0.5	0.4	0	50.3	52.5	0	145	150	0	28	28
2025	10	17	0	0	0	30.9	-1.8	1.041	0.4	0.3	0	50.3	52.5	0	145	150	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	17	0	10	0	31.1	-1.5	1.041	0.5	0.4	0	50.3	52.5	0	145	150	0	28	28
2025	10	17	0	20	0	31.8	-1.9	1.041	0.4	0.3	0	50.7	52.5	0	145	150	0	27	28
2025	10	17	0	30	0	30.4	-1.6	1.041	0.5	0.5	0	50.3	52.5	0	145	150	0	28	28
2025	10	17	0	40	0	30.1	-1.5	1.041	0.4	0.3	0	50.7	52.5	0	145	150	0	27	28
2025	10	17	0	50	0	31.8	-2.2	1.041	0.4	0.3	0	49.9	52.5	0	144	150	0	28	28
2025	10	17	1	0	0	31.5	-1.8	1.041	0.4	0.3	0	50.3	52.9	0	145	150	0	28	27
2025	10	17	1	10	0	30.5	-1.6	1.041	0.5	0.4	0	52	52.5	0	148	150	0	27	28
2025	10	17	1	20	0	31.4	-2.4	1.04	0.4	0.3	0	52	52.5	0	148	150	0	27	28
2025	10	17	1	30	0	31	-1.6	1.04	0.3	0.2	0	52	52.5	0	148	150	0	27	28
2025	10	17	1	40	0	31.5	-1	1.04	0.5	0.4	0	51.6	52.5	0	148	150	0	28	28
2025	10	17	1	50	0	29.9	-0.8	1.04	0.4	0.3	0	52.5	52.9	0	149	151	0	27	28
2025	10	17	2	0	0	31.4	-1.8	1.04	0.5	0.4	0	52	52.9	0	148	150	0	27	27
2025	10	17	2	10	0	30.5	-1.7	1.04	0.5	0.4	0	51.6	52.5	0	148	150	0	28	28
2025	10	17	2	20	0	31.4	-2.4	1.04	0.4	0.3	0	52	52.5	0	148	150	0	27	28
2025	10	17	2	30	0	30.6	-2	1.04	0.4	0.3	0	51.6	52.9	0	148	150	0	28	27
2025	10	17	2	40	0	31	-1.6	1.04	0.5	0.4	0	51.6	52.5	0	148	150	0	28	28
2025	10	17	2	50	0	30.6	-1.6	1.04	0.4	0.3	0	51.6	52.5	0	148	150	0	28	28
2025	10	17	3	0	0	30.8	-2.2	1.039	0.3	0.2	0	52	53.3	0	148	151	0	27	27
2025	10	17	3	10	0	31.4	-2.2	1.039	0.4	0.3	0	51.6	52.9	0	148	151	0	28	28
2025	10	17	3	20	0	30.6	-2.2	1.039	0.4	0.3	0	52.5	52.9	0	149	151	0	27	28
2025	10	17	3	30	0	31	-1.3	1.04	0.4	0.3	0	52	52.9	0	148	151	0	27	28
2025	10	17	3	40	0	31.7	-2.4	1.039	0.4	0.3	0	51.6	52.5	0	148	150	0	28	28
2025	10	17	3	50	0	30.7	-1.5	1.039	0.4	0.3	0	52	52.5	0	148	150	0	27	28
2025	10	17	4	0	0	30.7	-1.3	1.039	0.4	0.3	0	51.6	52.5	0	148	150	0	28	28
2025	10	17	4	10	0	31	-2.1	1.04	0.5	0.4	0	51.6	52.9	0	148	150	0	28	27
2025	10	17	4	20	0	31.2	-2	1.039	0.4	0.3	0	52	52.5	0	148	150	0	27	28
2025	10	17	4	30	0	30	-1.9	1.039	0.6	0.5	0	52	52	0	148	150	0	27	29
2025	10	17	4	40	0	32.2	-1.8	1.039	0.4	0.3	0	51.2	52.5	0	147	150	0	28	28
2025	10	17	4	50	0	31.3	-1.7	1.039	0.4	0.3	0	52	52.5	0	148	150	0	27	28
2025	10	17	5	0	0	30.9	-1.5	1.039	0.5	0.4	0	51.2	52.5	0	147	150	0	28	28
2025	10	17	5	10	0	31.3	-1.9	1.039	0.5	0.5	0	51.6	52.5	0	148	150	0	28	28
2025	10	17	5	20	0	31.4	-1.9	1.039	0.3	0.2	0	51.6	52.5	0	147	150	0	27	28
2025	10	17	5	30	0	31.7	-2.9	1.039	0.4	0.3	0	51.2	52.5	0	147	150	0	28	28
2025	10	17	5	40	0	31.4	-1.8	1.039	0.4	0.3	0	51.2	52.5	0	147	150	0	28	28
2025	10	17	5	50	0	30.5	-1.6	1.039	0.3	0.2	0	51.6	52.5	0	147	150	0	27	28
2025	10	17	6	0	0	31.2	-1.2	1.039	0.5	0.5	0	52	52.5	0	148	150	0	27	28
2025	10	17	6	10	0	30.1	-1.5	1.039	0.5	0.4	0	51.6	52.5	0	147	150	0	27	28
2025	10	17	6	20	0	31.1	-0.9	1.039	0.4	0.3	0	51.2	52.5	0	147	150	0	28	28
2025	10	17	6	30	0	31.3	-1.9	1.039	0.4	0.3	0	51.2	52	0	147	150	0	28	29
2025	10	17	6	40	0	30.6	-0.9	1.039	0.3	0.2	0	51.2	52.5	0	147	150	0	28	28
2025	10	17	6	50	0	31.2	-2.8	1.039	0.4	0.3	0	51.2	52.5	0	147	150	0	28	28
2025	10	17	7	0	0	30.5	-1.6	1.039	0.4	0.3	0	51.2	52.5	0	147	150	0	28	28
2025	10	17	7	10	0	30.9	-2.1	1.039	0.5	0.4	0	51.6	52.5	0	147	150	0	27	28
2025	10	17	7	20	0	31.3	-1.9	1.039	0.3	0.2	0	50.7	52	0	146	149	0	28	28
2025	10	17	7	30	0	31.3	-2.8	1.039	0.4	0.3	0	50.7	52	0	146	149	0	28	28
2025	10	17	7	40	0	30.6	-1.9	1.039	0.5	0.4	0	51.2	52	0	147	149	0	28	28
2025	10	17	7	50	0	30.6	-1.9	1.039	0.4	0.3	0	51.6	52	0	147	149	0	27	28
2025	10	17	8	0	0	31.3	-2	1.039	0.4	0.3	0	50.7	51.6	0	146	148	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	17	8	10	0	31.4	-1.4	1.039	0.4	0.3	0	50.7	51.6	0	146	148	0	28	28
2025	10	17	8	20	0	30.2	-1.3	1.039	0.4	0.3	0	50.3	51.6	0	145	148	0	28	28
2025	10	17	8	30	0	30.2	-1.6	1.039	0.4	0.3	0	51.2	51.6	0	146	148	0	27	28
2025	10	17	8	40	0	30	-1.9	1.039	0.4	0.3	0	50.3	51.2	0	145	148	0	28	29
2025	10	17	8	50	0	31.1	-0.9	1.039	0.5	0.4	0	50.3	50.7	0	144	147	0	27	29
2025	10	17	9	0	0	31	-1.8	1.039	0.3	0.2	0	49.9	50.7	0	144	147	0	28	29
2025	10	17	9	10	0	31.7	-2.6	1.039	0.5	0.4	0	49.5	50.7	0	143	146	0	28	28
2025	10	17	9	20	0	30.9	-1.9	1.039	0.4	0.3	0	49.5	50.7	0	143	146	0	28	28
2025	10	17	9	30	0	31.4	-3.2	1.039	0.5	0.5	0	49.5	50.7	0	143	146	0	28	28
2025	10	17	9	40	0	30	-0.9	1.039	0.3	0.2	0	49.5	50.3	0	142	145	0	27	28
2025	10	17	9	50	0	30.2	-0.9	1.038	0.5	0.4	0	49.5	50.7	0	142	145	0	27	27
2025	10	17	10	0	0	31	-2.1	1.039	0.6	0.5	0	50.3	49.5	0	144	144	0	27	29
2025	10	17	10	10	0	30.5	-0.9	1.038	0.5	0.4	0	49.9	50.3	0	144	145	0	28	28
2025	10	17	10	20	0	31.4	-1.6	1.037	0.5	0.4	0	50.3	50.7	0	145	146	0	28	28
2025	10	17	10	30	0	29.7	-2	1.037	0.4	0.3	0	50.7	51.2	0	146	147	0	28	28
2025	10	17	10	40	0	30.1	-1.8	1.037	0.5	0.4	0	51.2	51.2	0	147	147	0	28	28
2025	10	17	10	50	0	30.3	-2.2	1.037	0.4	0.3	0	50.3	51.2	0	145	147	0	28	28
2025	10	17	11	0	0	30.1	-1.3	1.036	0.3	0.2	0	51.2	51.2	0	147	148	0	28	29
2025	10	17	11	10	0	30.7	-2.7	1.036	0.4	0.3	0	51.2	51.2	0	146	147	0	27	28
2025	10	17	11	20	0	30.3	-1.6	1.036	0.5	0.4	0	51.2	51.6	0	147	148	0	28	28
2025	10	17	11	30	0	30.6	-0.7	1.036	0.4	0.3	0	50.3	50.7	0	145	146	0	28	28
2025	10	17	11	40	0	30	-1.2	1.036	0.5	0.4	0	50.7	50.3	0	145	146	0	27	29
2025	10	17	11	50	0	30.8	-2	1.036	0.5	0.4	0	50.3	50.7	0	145	146	0	28	28
2025	10	17	12	0	0	31.3	-2	1.036	0.4	0.3	0	50.3	50.3	0	144	145	0	27	28
2025	10	17	12	10	0	31.6	-2.4	1.036	0.4	0.3	0	49.9	50.3	0	144	145	0	28	28
2025	10	17	12	20	0	30.4	-2.1	1.036	0.4	0.3	0	49.9	50.7	0	144	146	0	28	28
2025	10	17	12	30	0	32.1	-1.9	1.036	0.5	0.5	0	49.9	50.3	0	144	145	0	28	28
2025	10	17	12	40	0	30.1	-1.6	1.036	0.4	0.3	0	49.9	50.3	0	144	145	0	28	28
2025	10	17	12	50	0	31.4	-1.8	1.036	0.5	0.5	0	49.9	49.9	0	143	144	0	27	28
2025	10	17	13	0	0	31.6	-1.3	1.036	0.3	0.2	0	49.9	50.7	0	144	145	0	28	27
2025	10	17	13	10	0	30.1	-2.1	1.036	0.5	0.4	0	49.9	50.3	0	144	145	0	28	28
2025	10	17	13	20	0	31.8	-0.8	1.035	0.5	0.4	0	49.9	50.3	0	144	145	0	28	28
2025	10	17	13	30	0	30	-1.5	1.035	0.4	0.3	0	49.5	50.3	0	143	145	0	28	28
2025	10	17	13	40	0	30.9	-0.1	1.035	0.4	0.3	0	49.5	50.3	0	143	145	0	28	28
2025	10	17	13	50	0	31	-1.8	1.035	0.4	0.3	0	49.5	50.3	0	143	145	0	28	28
2025	10	17	14	0	0	30.1	-1.7	1.035	0.3	0.2	0	49.9	50.3	0	143	145	0	27	28
2025	10	17	14	10	0	30.1	-0.6	1.035	0.4	0.3	0	49.9	50.3	0	144	145	0	28	28
2025	10	17	14	20	0	30.2	-1	1.035	0.4	0.3	0	50.3	50.7	0	144	145	0	27	27
2025	10	17	14	30	0	31	-1.8	1.035	0.5	0.5	0	49.9	50.3	0	143	145	0	27	28
2025	10	17	14	40	0	31.2	-1.4	1.035	0.5	0.4	0	49.9	50.7	0	143	145	0	27	27
2025	10	17	14	50	0	31.1	-1.1	1.035	0.5	0.4	0	50.3	50.7	0	144	146	0	27	28
2025	10	17	15	0	0	30.8	-1.5	1.035	0.5	0.4	0	49.9	50.3	0	144	145	0	28	28
2025	10	17	15	10	0	30.8	-2.7	1.035	0.5	0.4	0	49.9	50.7	0	144	146	0	28	28
2025	10	17	15	20	0	31	-1.5	1.035	0.5	0.4	0	49.9	51.2	0	144	146	0	28	27
2025	10	17	15	30	0	31.3	-1.5	1.035	0.5	0.4	0	50.3	51.2	0	144	146	0	27	27
2025	10	17	15	40	0	30.2	-1.7	1.035	0.6	0.5	0	50.3	51.2	0	144	146	0	27	27
2025	10	17	15	50	0	30.5	-1.7	1.035	0.3	0.2	0	50.7	51.2	0	145	146	0	27	27
2025	10	17	16	0	0	29.6	-1.6	1.035	0.4	0.3	0	50.3	51.2	0	145	147	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	17	16	10	0	31.1	-0.8	1.035	0.5	0.4	0	50.7	51.2	0	145	147	0	27	28
2025	10	17	16	20	0	31	-1.6	1.035	0.3	0.2	0	50.3	50.7	0	145	146	0	28	28
2025	10	17	16	30	0	31	-1.7	1.035	0.5	0.5	0	50.3	51.2	0	145	147	0	28	28
2025	10	17	16	40	0	30.2	-1.7	1.035	0.5	0.4	0	50.7	50.7	0	145	146	0	27	28
2025	10	17	16	50	0	29.2	-1.1	1.035	0.4	0.3	0	50.3	51.2	0	145	147	0	28	28
2025	10	17	17	0	0	30.5	-2.3	1.035	0.5	0.4	0	50.7	51.2	0	146	147	0	28	28
2025	10	17	17	10	0	31.2	-1.6	1.035	0.4	0.3	0	51.2	51.6	0	146	148	0	27	28
2025	10	17	17	20	0	31.3	-2.7	1.035	0.5	0.4	0	50.7	51.2	0	145	147	0	27	28
2025	10	17	17	30	0	31.5	-1.8	1.035	0.5	0.4	0	50.7	50.7	0	145	146	0	27	28
2025	10	17	17	40	0	30.7	-2.3	1.035	0.4	0.3	0	50.7	51.2	0	145	146	0	27	27
2025	10	17	17	50	0	31.2	-2	1.035	0.5	0.5	0	50.7	51.2	0	145	147	0	27	28
2025	10	17	18	0	0	30.7	-1.8	1.035	0.5	0.4	0	50.3	50.7	0	145	146	0	28	28
2025	10	17	18	10	0	30.9	-2	1.035	0.3	0.2	0	49.9	50.7	0	144	146	0	28	28
2025	10	17	18	20	0	30.6	-2.6	1.035	0.5	0.5	0	50.7	51.6	0	145	147	0	27	27
2025	10	17	18	30	0	30.9	-1.9	1.035	0.5	0.4	0	50.7	51.2	0	145	147	0	27	28
2025	10	17	18	40	0	30.7	-2	1.035	0.5	0.4	0	51.2	51.6	0	146	147	0	27	27
2025	10	17	18	50	0	30.7	-1.3	1.035	0.5	0.4	0	50.7	52	0	146	148	0	28	27
2025	10	17	19	0	0	30.5	-1.9	1.035	0.5	0.4	0	51.6	51.6	0	146	148	0	26	28
2025	10	17	19	10	0	29.5	-0.8	1.035	0.5	0.5	0	51.6	52	0	147	148	0	27	27
2025	10	17	19	20	0	31.3	-1.9	1.035	0.5	0.4	0	51.2	51.6	0	146	148	0	27	28
2025	10	17	19	30	0	31.3	-2.1	1.035	0.4	0.3	0	51.2	52	0	147	149	0	28	28
2025	10	17	19	40	0	29.6	-1	1.035	0.5	0.4	0	51.2	52	0	147	149	0	28	28
2025	10	17	19	50	0	31.4	-1.4	1.034	0.5	0.4	0	51.6	52.5	0	147	149	0	27	27
2025	10	17	20	0	0	30.6	-1.9	1.035	0.5	0.4	0	51.6	52	0	147	149	0	27	28
2025	10	17	20	10	0	30	-1.5	1.035	0.4	0.3	0	51.6	52	0	148	149	0	28	28
2025	10	17	20	20	0	30.5	-1.2	1.035	0.4	0.3	0	51.6	52	0	147	149	0	27	28
2025	10	17	20	30	0	31.3	-1.2	1.035	0.4	0.3	0	51.2	52.5	0	147	150	0	28	28
2025	10	17	20	40	0	31.2	-0.7	1.035	0.5	0.4	0	52	52.5	0	148	150	0	27	28
2025	10	17	20	50	0	32	-1.8	1.034	0.3	0.2	0	52	52.9	0	148	150	0	27	27
2025	10	17	21	0	0	30	-2.3	1.034	0.4	0.3	0	51.6	52.5	0	148	150	0	28	28
2025	10	17	21	10	0	31.2	-1.1	1.034	0.5	0.4	0	52	52.5	0	148	150	0	27	28
2025	10	17	21	20	0	30.9	-1.9	1.034	0.4	0.3	0	52	52.5	0	148	150	0	27	28
2025	10	17	21	30	0	30.7	-1.8	1.034	0.5	0.4	0	52.5	52.9	0	149	151	0	27	28
2025	10	17	21	40	0	30.4	-1.6	1.034	0.4	0.3	0	51.6	52.5	0	148	150	0	28	28
2025	10	17	21	50	0	31.6	-1.8	1.034	0.5	0.4	0	51.6	52.5	0	148	150	0	28	28
2025	10	17	22	0	0	30.7	-1.5	1.034	0.3	0.2	0	51.6	52.9	0	148	151	0	28	28
2025	10	17	22	10	0	30.6	-0.8	1.034	0.4	0.3	0	51.6	52.9	0	148	151	0	28	28
2025	10	17	22	20	0	30.5	-1.2	1.034	0.4	0.3	0	51.6	52.5	0	148	150	0	28	28
2025	10	17	22	30	0	30.7	-2.4	1.034	0.3	0.2	0	51.6	52.5	0	148	150	0	28	28
2025	10	17	22	40	0	29.9	-1.9	1.034	0.5	0.4	0	51.6	52.9	0	148	150	0	28	27
2025	10	17	22	50	0	30.4	-1.9	1.034	0.5	0.4	0	51.6	52.5	0	147	150	0	27	28
2025	10	17	23	0	0	30.6	-1.7	1.034	0.5	0.4	0	52	52.5	0	148	150	0	27	28
2025	10	17	23	10	0	30.8	-2	1.034	0.5	0.4	0	51.6	52.5	0	148	150	0	28	28
2025	10	17	23	20	0	30.6	-1.8	1.034	0.5	0.4	0	51.6	52.5	0	147	150	0	27	28
2025	10	17	23	30	0	31.3	-0.7	1.034	0.4	0.3	0	52	52.5	0	148	150	0	27	28
2025	10	17	23	40	0	30.5	-2.6	1.034	0.5	0.4	0	51.6	52.5	0	147	150	0	27	28
2025	10	17	23	50	0	29.7	-1.8	1.034	0.5	0.4	0	51.6	52.5	0	147	150	0	27	28
2025	10	18	0	0	0	31.5	-1.7	1.033	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	18	0	10	0	30	-1.7	1.033	0.4	0.3	0	51.6	52.5	0	147	150	0	27	28
2025	10	18	0	20	0	30.5	-1.9	1.033	0.4	0.3	0	51.2	52.5	0	147	150	0	28	28
2025	10	18	0	30	0	31.7	-2.3	1.033	0.5	0.4	0	51.2	52.5	0	147	150	0	28	28
2025	10	18	0	40	0	31.3	-2.5	1.033	0.5	0.4	0	51.2	52.5	0	147	150	0	28	28
2025	10	18	0	50	0	31.7	-2.1	1.033	0.5	0.4	0	51.2	52.5	0	147	150	0	28	28
2025	10	18	1	0	0	31.9	-1.6	1.033	0.5	0.5	0	51.2	52.5	0	147	150	0	28	28
2025	10	18	1	10	0	30.8	-2.4	1.033	0.5	0.4	0	51.2	52.5	0	147	150	0	28	28
2025	10	18	1	20	0	30.3	-2.1	1.033	0.5	0.4	0	51.2	52.5	0	147	150	0	28	28
2025	10	18	1	30	0	30.9	-2	1.033	0.5	0.4	0	51.2	52.5	0	147	150	0	28	28
2025	10	18	1	40	0	30.9	-1.5	1.033	0.5	0.4	0	51.2	52	0	147	149	0	28	28
2025	10	18	1	50	0	30.7	-2	1.033	0.5	0.4	0	51.2	52.5	0	147	150	0	28	28
2025	10	18	2	0	0	30.2	-2.8	1.033	0.4	0.3	0	51.2	52.5	0	147	150	0	28	28
2025	10	18	2	10	0	31.3	-1.7	1.033	0.4	0.3	0	51.2	51.6	0	146	149	0	27	29
2025	10	18	2	20	0	30.7	-1.7	1.033	0.4	0.3	0	51.2	52	0	147	149	0	28	28
2025	10	18	2	30	0	31.1	-0.8	1.033	0.3	0.2	0	51.6	52.5	0	147	150	0	27	28
2025	10	18	2	40	0	30.3	-2	1.033	0.4	0.3	0	50.7	52	0	146	149	0	28	28
2025	10	18	2	50	0	31.6	-2.5	1.033	0.4	0.3	0	51.2	52	0	146	149	0	27	28
2025	10	18	3	0	0	30.8	-3.2	1.033	0.5	0.4	0	50.7	52	0	146	149	0	28	28
2025	10	18	3	10	0	30.7	-2.7	1.033	0.4	0.3	0	49.9	52	0	144	149	0	28	28
2025	10	18	3	20	0	31.1	-1.6	1.033	0.4	0.3	0	52	52	0	149	149	0	28	28
2025	10	18	3	30	0	30.9	-2.1	1.032	0.3	0.2	0	52.5	52	0	149	149	0	27	28
2025	10	18	3	40	0	30.5	-0.9	1.033	0.3	0.2	0	52	52	0	149	149	0	28	28
2025	10	18	3	50	0	31	-2.4	1.033	0.3	0.2	0	51.6	51.6	0	148	149	0	28	29
2025	10	18	4	0	0	30.9	-2.1	1.033	0.4	0.3	0	52	52	0	149	149	0	28	28
2025	10	18	4	10	0	31.2	-1.8	1.032	0.5	0.5	0	52	52	0	149	149	0	28	28
2025	10	18	4	20	0	30.7	-1.5	1.032	0.3	0.2	0	51.6	52	0	148	149	0	28	28
2025	10	18	4	30	0	30.8	-0.9	1.032	0.5	0.4	0	52	52	0	149	149	0	28	28
2025	10	18	4	40	0	29.8	-1.2	1.033	0.4	0.3	0	51.6	52	0	148	149	0	28	28
2025	10	18	4	50	0	30.4	-1.3	1.032	0.4	0.3	0	52	52	0	149	149	0	28	28
2025	10	18	5	0	0	30.3	-1.2	1.033	0.4	0.3	0	52	52.9	0	149	150	0	28	27
2025	10	18	5	10	0	31.2	-2	1.032	0.5	0.4	0	51.6	52	0	148	149	0	28	28
2025	10	18	5	20	0	31.2	-1.2	1.032	0.4	0.3	0	52	52	0	148	149	0	27	28
2025	10	18	5	30	0	30.6	-2	1.032	0.4	0.3	0	52	52	0	148	149	0	27	28
2025	10	18	5	40	0	30.6	-2.4	1.032	0.5	0.4	0	51.6	51.6	0	148	148	0	28	28
2025	10	18	5	50	0	31.8	-1.6	1.032	0.4	0.3	0	51.6	51.6	0	148	149	0	28	29
2025	10	18	6	0	0	31	-1.6	1.032	0.4	0.3	0	51.6	51.2	0	148	148	0	28	29
2025	10	18	6	10	0	31.1	-2.8	1.032	0.5	0.4	0	51.6	52	0	147	148	0	27	27
2025	10	18	6	20	0	30.9	-2.7	1.032	0.4	0.3	0	51.2	51.2	0	147	148	0	28	29
2025	10	18	6	30	0	31.2	-2.8	1.032	0.6	0.5	0	51.2	51.6	0	147	148	0	28	28
2025	10	18	6	40	0	31.2	-2.1	1.032	0.4	0.3	0	51.2	51.2	0	147	148	0	28	29
2025	10	18	6	50	0	30.7	-2.1	1.032	0.4	0.3	0	51.2	51.2	0	147	148	0	28	29
2025	10	18	7	0	0	30.5	-1.9	1.032	0.4	0.3	0	51.2	51.6	0	147	148	0	28	28
2025	10	18	7	10	0	30.8	-2	1.032	0.4	0.3	0	51.2	51.6	0	147	148	0	28	28
2025	10	18	7	20	0	31.1	-1.6	1.032	0.4	0.3	0	50.7	51.6	0	146	148	0	28	28
2025	10	18	7	30	0	30.5	-2	1.032	0.3	0.2	0	51.2	50.7	0	146	147	0	27	29
2025	10	18	7	40	0	30.9	-0.5	1.032	0.5	0.4	0	50.7	50.7	0	146	147	0	28	29
2025	10	18	7	50	0	30.6	-3.2	1.032	0.3	0.2	0	50.7	50.7	0	145	146	0	27	28
2025	10	18	8	0	0	31.3	-1.9	1.032	0.4	0.3	0	50.3	50.3	0	145	146	0	28	29

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	18	8	10	0	30.6	-2.2	1.032	0.3	0.2	0	50.3	50.7	0	145	146	0	28	28
2025	10	18	8	20	0	30.8	-1.8	1.032	0.4	0.3	0	49.9	50.3	0	144	145	0	28	28
2025	10	18	8	30	0	31.7	-1.3	1.032	0.5	0.4	0	49.5	50.3	0	143	145	0	28	28
2025	10	18	8	40	0	31.4	-2	1.032	0.5	0.5	0	49.5	50.3	0	143	145	0	28	28
2025	10	18	8	50	0	30.3	-0.8	1.032	0.3	0.2	0	49.5	49.5	0	143	144	0	28	29
2025	10	18	9	0	0	29.8	-1.4	1.032	0.5	0.5	0	49	49	0	142	143	0	28	29
2025	10	18	9	10	0	31	-1.6	1.032	0.5	0.4	0	48.6	49.5	0	141	143	0	28	28
2025	10	18	9	20	0	30.4	-2	1.033	0.4	0.3	0	49	49	0	141	142	0	27	28
2025	10	18	9	30	0	30.5	0.2	1.033	0.4	0.3	0	48.6	49	0	140	142	0	27	28
2025	10	18	9	40	0	30.7	-1.5	1.033	0.4	0.3	0	48.2	48.6	0	140	142	0	28	29
2025	10	18	9	50	0	30.9	-1.3	1.033	0.4	0.3	0	48.6	48.6	0	140	141	0	27	28
2025	10	18	10	0	0	31.3	-1.8	1.033	0.4	0.3	0	47.3	48.6	0	138	141	0	28	28
2025	10	18	10	10	0	30.5	-2.2	1.033	0.4	0.3	0	47.7	48.6	0	139	142	0	28	29
2025	10	18	10	20	0	30.2	-1.3	1.033	0.3	0.2	0	47.3	48.6	0	138	141	0	28	28
2025	10	18	10	30	0	31.3	-2	1.033	0.3	0.2	0	48.6	48.6	0	140	141	0	27	28
2025	10	18	10	40	0	30.2	-1.6	1.033	0.5	0.4	0	47.7	48.2	0	139	140	0	28	28
2025	10	18	10	50	0	30.4	-1.5	1.033	0.3	0.2	0	47.7	48.2	0	139	140	0	28	28
2025	10	18	11	0	0	31.1	-1.7	1.033	0.3	0.2	0	46.9	47.7	0	137	139	0	28	28
2025	10	18	11	10	0	30.8	-1.7	1.033	0.5	0.4	0	47.3	48.2	0	138	140	0	28	28
2025	10	18	11	20	0	30.5	-2	1.033	0.4	0.3	0	46.9	47.7	0	137	139	0	28	28
2025	10	18	11	30	0	31.2	-2.1	1.033	0.4	0.3	0	46.9	48.2	0	137	139	0	28	27
2025	10	18	11	40	0	30.1	-1.6	1.033	0.4	0.3	0	46.9	47.3	0	137	139	0	28	29
2025	10	18	11	50	0	31.1	-2.4	1.033	0.4	0.3	0	47.3	46.9	0	137	138	0	27	29
2025	10	18	12	0	0	30.4	-2.5	1.033	0.4	0.3	0	46.9	47.7	0	137	139	0	28	28
2025	10	18	12	10	0	31.2	-1.2	1.033	0.4	0.3	0	47.7	48.2	0	138	140	0	27	28
2025	10	18	12	20	0	30.8	-1.6	1.033	0.5	0.4	0	47.3	48.2	0	138	140	0	28	28
2025	10	18	12	30	0	30.1	-1.3	1.033	0.5	0.4	0	47.3	47.7	0	138	139	0	28	28
2025	10	18	12	40	0	30.8	-2.6	1.033	0.3	0.2	0	47.7	47.3	0	138	139	0	27	29
2025	10	18	12	50	0	30.6	-1.5	1.034	0.4	0.3	0	46.9	47.7	0	137	139	0	28	28
2025	10	18	13	0	0	30.1	-2	1.034	0.4	0.3	0	47.3	47.3	0	137	139	0	27	29
2025	10	18	13	10	0	29.7	-2.4	1.033	0.3	0.2	0	47.3	47.7	0	137	139	0	27	28
2025	10	18	13	20	0	30.6	-2.6	1.034	0.5	0.4	0	47.3	47.7	0	138	139	0	28	28
2025	10	18	13	30	0	30.7	-2.9	1.034	0.4	0.3	0	47.3	47.7	0	137	139	0	27	28
2025	10	18	13	40	0	31.6	-1.5	1.034	0.5	0.4	0	47.3	47.7	0	137	139	0	27	28
2025	10	18	13	50	0	31.6	-1.2	1.034	0.5	0.4	0	47.7	48.2	0	138	140	0	27	28
2025	10	18	14	0	0	31.4	-2.9	1.034	0.5	0.4	0	47.7	48.6	0	139	141	0	28	28
2025	10	18	14	10	0	30.7	-1.7	1.034	0.5	0.4	0	47.7	48.2	0	138	140	0	27	28
2025	10	18	14	20	0	31.5	-2.6	1.034	0.5	0.4	0	46.9	47.7	0	137	139	0	28	28
2025	10	18	14	30	0	31.1	-2.2	1.034	0.5	0.4	0	46.9	47.7	0	137	139	0	28	28
2025	10	18	14	40	0	29.8	-2.2	1.034	0.5	0.4	0	47.7	48.6	0	138	141	0	27	28
2025	10	18	14	50	0	31	-2.5	1.034	0.5	0.4	0	48.2	49	0	139	141	0	27	27
2025	10	18	15	0	0	31.1	-1.7	1.033	0.3	0.2	0	48.2	48.6	0	139	141	0	27	28
2025	10	18	15	10	0	30.9	-1.6	1.033	0.5	0.4	0	47.7	49	0	139	142	0	28	28
2025	10	18	15	20	0	31.3	-1.8	1.033	0.5	0.4	0	47.7	49	0	139	141	0	28	27
2025	10	18	15	30	0	32.4	-2	1.033	0.4	0.3	0	47.3	48.2	0	138	140	0	28	28
2025	10	18	15	40	0	30.9	-2.4	1.033	0.3	0.2	0	47.3	48.2	0	138	140	0	28	28
2025	10	18	15	50	0	30.4	-2.5	1.034	0.4	0.3	0	47.7	49	0	139	141	0	28	27
2025	10	18	16	0	0	31.3	-1.7	1.034	0.4	0.3	0	48.6	49	0	140	142	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	18	16	10	0	31.1	-2.5	1.033	0.4	0.3	0	48.6	49	0	141	142	0	28	28
2025	10	18	16	20	0	31	-2.3	1.033	0.5	0.4	0	48.6	49.5	0	141	143	0	28	28
2025	10	18	16	30	0	30.5	-1.5	1.034	0.5	0.5	0	48.2	48.6	0	140	142	0	28	29
2025	10	18	16	40	0	30.5	-1.8	1.033	0.4	0.3	0	49	49.5	0	141	143	0	27	28
2025	10	18	16	50	0	32.1	-1.9	1.034	0.5	0.4	0	47.7	49	0	139	141	0	28	27
2025	10	18	17	0	0	30.3	-2.4	1.034	0.4	0.3	0	48.2	48.6	0	139	141	0	27	28
2025	10	18	17	10	0	31.5	-1.2	1.034	0.4	0.3	0	48.2	48.6	0	140	141	0	28	28
2025	10	18	17	20	0	30.9	-1.8	1.034	0.4	0.3	0	48.2	49	0	140	142	0	28	28
2025	10	18	17	30	0	31.9	-1.6	1.034	0.3	0.2	0	47.7	48.6	0	139	141	0	28	28
2025	10	18	17	40	0	29.4	-2.1	1.034	0.3	0.2	0	48.6	49	0	140	141	0	27	27
2025	10	18	17	50	0	31.9	-1.4	1.034	0.4	0.3	0	48.6	48.6	0	140	141	0	27	28
2025	10	18	18	0	0	30.6	-1.7	1.034	0.5	0.4	0	48.2	49	0	140	142	0	28	28
2025	10	18	18	10	0	30.3	-2.1	1.034	0.5	0.4	0	48.2	48.6	0	139	141	0	27	28
2025	10	18	18	20	0	30.9	-2.5	1.034	0.5	0.4	0	48.6	49	0	140	141	0	27	27
2025	10	18	18	30	0	30.6	-1.6	1.034	0.4	0.3	0	49	49	0	141	142	0	27	28
2025	10	18	18	40	0	30.5	-1.4	1.034	0.4	0.3	0	48.2	49	0	140	142	0	28	28
2025	10	18	18	50	0	29.9	-1.8	1.034	0.4	0.3	0	48.6	49	0	141	142	0	28	28
2025	10	18	19	0	0	29.6	-1.8	1.034	0.5	0.4	0	49	49.5	0	141	143	0	27	28
2025	10	18	19	10	0	31.2	-2.1	1.034	0.5	0.4	0	48.6	49.5	0	141	143	0	28	28
2025	10	18	19	20	0	30.9	-1.7	1.034	0.5	0.4	0	49.5	49.5	0	142	143	0	27	28
2025	10	18	19	30	0	31.2	-1.5	1.034	0.4	0.3	0	49.5	49.5	0	142	143	0	27	28
2025	10	18	19	40	0	30.9	-1.5	1.034	0.5	0.4	0	49.5	49.9	0	142	144	0	27	28
2025	10	18	19	50	0	31.5	-1.2	1.034	0.5	0.4	0	49	50.3	0	142	144	0	28	27
2025	10	18	20	0	0	31.3	-2.4	1.034	0.5	0.4	0	49	49.9	0	142	144	0	28	28
2025	10	18	20	10	0	31	-2.3	1.034	0.4	0.3	0	49.5	49.5	0	142	144	0	27	29
2025	10	18	20	20	0	30.8	-0.9	1.034	0.5	0.4	0	49.5	50.3	0	143	144	0	28	27
2025	10	18	20	30	0	32	-2	1.034	0.5	0.5	0	49.5	50.3	0	143	145	0	28	28
2025	10	18	20	40	0	30.3	-0.3	1.034	0.5	0.4	0	49.9	50.3	0	143	145	0	27	28
2025	10	18	20	50	0	31	-1.8	1.034	0.5	0.5	0	49.9	50.3	0	143	145	0	27	28
2025	10	18	21	0	0	30.4	-2.4	1.034	0.4	0.3	0	49.9	50.3	0	143	145	0	27	28
2025	10	18	21	10	0	30.9	-2	1.034	0.3	0.2	0	49.9	50.3	0	143	145	0	27	28
2025	10	18	21	20	0	30.7	-1.8	1.034	0.5	0.4	0	49	49.9	0	142	144	0	28	28
2025	10	18	21	30	0	30.6	-0.9	1.034	0.4	0.3	0	49.5	50.3	0	143	145	0	28	28
2025	10	18	21	40	0	30.7	-1.9	1.034	0.5	0.4	0	49.9	50.3	0	143	145	0	27	28
2025	10	18	21	50	0	29.9	-1.7	1.033	0.3	0.2	0	49.9	50.3	0	143	145	0	27	28
2025	10	18	22	0	0	30.6	-2.5	1.033	0.4	0.3	0	49.5	50.3	0	143	145	0	28	28
2025	10	18	22	10	0	31.1	-2.1	1.033	0.5	0.5	0	49.9	50.7	0	143	145	0	27	27
2025	10	18	22	20	0	30.1	-2.5	1.033	0.5	0.4	0	49.9	50.7	0	143	146	0	27	28
2025	10	18	22	30	0	30.3	-0.7	1.033	0.5	0.4	0	49.5	50.3	0	143	145	0	28	28
2025	10	18	22	40	0	31	-1.7	1.033	0.5	0.4	0	49.5	50.7	0	143	146	0	28	28
2025	10	18	22	50	0	31.8	-1.5	1.033	0.3	0.2	0	49.5	50.3	0	143	145	0	28	28
2025	10	18	23	0	0	31	-1.2	1.033	0.5	0.4	0	50.3	51.2	0	144	146	0	27	27
2025	10	18	23	10	0	30.8	-2.1	1.033	0.5	0.4	0	50.3	51.2	0	145	146	0	28	27
2025	10	18	23	20	0	30.7	-1.7	1.033	0.5	0.4	0	50.3	49.9	0	145	145	0	28	29
2025	10	18	23	30	0	31.2	-1.6	1.033	0.3	0.2	0	50.3	50.3	0	145	145	0	28	28
2025	10	18	23	40	0	30.3	-2.4	1.033	0.4	0.3	0	50.3	50.7	0	145	145	0	28	27
2025	10	18	23	50	0	31.4	-1.8	1.033	0.3	0.2	0	50.3	50.3	0	145	146	0	28	29
2025	10	19	0	0	0	30.9	-2	1.033	0.4	0.3	0	50.3	50.3	0	145	145	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	19	0	10	0	30.5	-0.9	1.033	0.5	0.5	0	51.2	50.7	0	146	146	0	27	28
2025	10	19	0	20	0	30.6	-1.3	1.033	0.4	0.3	0	50.3	50.3	0	145	145	0	28	28
2025	10	19	0	30	0	31	-1.4	1.033	0.4	0.3	0	50.3	50.7	0	145	145	0	28	27
2025	10	19	0	40	0	30.4	-2.5	1.033	0.3	0.2	0	50.3	50.3	0	145	145	0	28	28
2025	10	19	0	50	0	30.5	-1.2	1.033	0.3	0.2	0	50.3	50.7	0	145	145	0	28	27
2025	10	19	1	0	0	31.1	-2.4	1.033	0.5	0.5	0	50.7	49.9	0	145	145	0	27	29
2025	10	19	1	10	0	30.3	-0.8	1.032	0.4	0.3	0	50.3	50.3	0	145	145	0	28	28
2025	10	19	1	20	0	30.7	-2.4	1.033	0.3	0.2	0	50.3	50.3	0	145	145	0	28	28
2025	10	19	1	30	0	30.4	-2.2	1.032	0.4	0.3	0	50.7	50.3	0	145	145	0	27	28
2025	10	19	1	40	0	30.7	-1.4	1.033	0.4	0.3	0	50.3	50.3	0	145	145	0	28	28
2025	10	19	1	50	0	30.6	-1.5	1.032	0.5	0.4	0	50.3	49.9	0	144	144	0	27	28
2025	10	19	2	0	0	30.5	-2.8	1.032	0.4	0.3	0	50.3	50.7	0	144	145	0	27	27
2025	10	19	2	10	0	31	-1.9	1.032	0.3	0.2	0	49.5	49.9	0	144	144	0	29	28
2025	10	19	2	20	0	30.6	-1.6	1.032	0.4	0.3	0	49.9	50.3	0	144	145	0	28	28
2025	10	19	2	30	0	31.1	-1.8	1.032	0.5	0.4	0	50.3	50.3	0	144	145	0	27	28
2025	10	19	2	40	0	30.5	-2.4	1.032	0.4	0.3	0	50.3	50.3	0	144	145	0	27	28
2025	10	19	2	50	0	30	-1.6	1.032	0.4	0.3	0	50.3	50.3	0	144	145	0	27	28
2025	10	19	3	0	0	30.5	-1.1	1.032	0.3	0.2	0	49.9	49.9	0	144	145	0	28	29
2025	10	19	3	10	0	31.2	-2.9	1.032	0.5	0.4	0	49.9	50.3	0	144	145	0	28	28
2025	10	19	3	20	0	30.3	-1.4	1.032	0.5	0.4	0	49.9	50.3	0	144	145	0	28	28
2025	10	19	3	30	0	31.2	-1.3	1.032	0.5	0.4	0	50.3	49.9	0	144	144	0	27	28
2025	10	19	3	40	0	32	-1.2	1.032	0.4	0.3	0	50.3	50.3	0	144	145	0	27	28
2025	10	19	3	50	0	29.5	-0.4	1.032	0.3	0.2	0	50.3	50.3	0	144	145	0	27	28
2025	10	19	4	0	0	30.7	-0.8	1.032	0.4	0.3	0	50.3	50.3	0	144	145	0	27	28
2025	10	19	4	10	0	31.3	-1.7	1.032	0.5	0.4	0	49.9	50.3	0	144	145	0	28	28
2025	10	19	4	20	0	31.2	-1.3	1.032	0.5	0.4	0	49.9	50.3	0	144	145	0	28	28
2025	10	19	4	30	0	30.2	-1.2	1.032	0.5	0.4	0	49.9	50.7	0	144	145	0	28	27
2025	10	19	4	40	0	30.3	-1.6	1.032	0.3	0.2	0	49.9	50.3	0	143	145	0	27	28
2025	10	19	4	50	0	31	-2.4	1.032	0.3	0.2	0	49.5	49.9	0	143	144	0	28	28
2025	10	19	5	0	0	30.9	-1	1.032	0.4	0.3	0	49.5	49.9	0	143	144	0	28	28
2025	10	19	5	10	0	31.2	-2.3	1.032	0.4	0.3	0	49.9	50.3	0	144	145	0	28	28
2025	10	19	5	20	0	30.8	-2.8	1.032	0.5	0.4	0	49.5	49.9	0	143	144	0	28	28
2025	10	19	5	30	0	30.7	-2.1	1.032	0.5	0.4	0	49.5	49.5	0	143	144	0	28	29
2025	10	19	5	40	0	31.5	-1.7	1.032	0.3	0.2	0	49.9	49.9	0	143	144	0	27	28
2025	10	19	5	50	0	31.1	-2.1	1.032	0.4	0.3	0	49.9	50.3	0	143	145	0	27	28
2025	10	19	6	0	0	31.5	-1.9	1.032	0.3	0.2	0	49.5	49.9	0	143	144	0	28	28
2025	10	19	6	10	0	30.9	-2	1.032	0.4	0.3	0	49.9	50.3	0	143	145	0	27	28
2025	10	19	6	20	0	31	-2.4	1.032	0.3	0.2	0	49.9	49.9	0	143	144	0	27	28
2025	10	19	6	30	0	31.2	-2.6	1.032	0.5	0.4	0	49.5	49.9	0	143	144	0	28	28
2025	10	19	6	40	0	30.6	-1.8	1.032	0.4	0.3	0	49.5	49.5	0	143	144	0	28	29
2025	10	19	6	50	0	30.8	-1.6	1.032	0.4	0.3	0	49.5	49.9	0	143	144	0	28	28
2025	10	19	7	0	0	30.7	-1.3	1.031	0.4	0.3	0	49.5	49.9	0	143	144	0	28	28
2025	10	19	7	10	0	29.9	-1	1.031	0.4	0.3	0	49.5	49.9	0	143	144	0	28	28
2025	10	19	7	20	0	31	-1.6	1.032	0.3	0.2	0	49.5	49.9	0	143	144	0	28	28
2025	10	19	7	30	0	30.9	-2	1.031	0.3	0.2	0	49	49.5	0	142	143	0	28	28
2025	10	19	7	40	0	30.5	-3	1.031	0.3	0.2	0	48.6	49	0	141	142	0	28	28
2025	10	19	7	50	0	30.6	-2.1	1.031	0.3	0.2	0	48.2	49	0	140	142	0	28	28
2025	10	19	8	0	0	30.4	-2.5	1.031	0.4	0.3	0	48.6	49	0	140	142	0	27	28

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	19	8	10	0	31.9	-2	1.031	0.4	0.3	0	48.2	49	0	140	142	0	28	28
2025	10	19	8	20	0	30.1	-1.7	1.031	0.4	0.3	0	47.7	48.6	0	139	141	0	28	28
2025	10	19	8	30	0	31.6	-2.2	1.031	0.4	0.3	0	47.7	48.6	0	139	141	0	28	28
2025	10	19	8	40	0	31.2	-1.2	1.031	0.5	0.4	0	48.2	48.2	0	139	140	0	27	28
2025	10	19	8	50	0	30.1	-1	1.031	0.4	0.3	0	47.3	48.2	0	138	140	0	28	28
2025	10	19	9	0	0	31.1	-2	1.031	0.5	0.4	0	46.9	47.7	0	137	139	0	28	28
2025	10	19	9	10	0	31.9	-2.2	1.031	0.4	0.3	0	46.9	47.7	0	137	139	0	28	28
2025	10	19	9	20	0	29.8	-2	1.031	0.3	0.2	0	47.7	47.7	0	138	139	0	27	28
2025	10	19	9	30	0	31	-0.9	1.031	0.4	0.3	0	47.3	47.7	0	138	139	0	28	28
2025	10	19	9	40	0	29	-1.2	1.031	0.4	0.3	0	47.3	47.7	0	137	139	0	27	28
2025	10	19	9	50	0	30.6	-1.4	1.031	0.4	0.3	0	46.4	46.4	0	136	137	0	28	29
2025	10	19	10	0	0	31.1	-0.9	1.031	0.3	0.2	0	46	46.9	0	135	137	0	28	28
2025	10	19	10	10	0	30.1	-1.5	1.031	0.5	0.4	0	46.9	47.3	0	137	138	0	28	28
2025	10	19	10	20	0	30.6	-2.3	1.031	0.3	0.2	0	46.4	46.9	0	136	137	0	28	28
2025	10	19	10	30	0	29.4	-2.5	1.031	0.5	0.4	0	46.9	47.3	0	136	138	0	27	28
2025	10	19	10	40	0	31.1	-2.8	1.03	0.5	0.4	0	48.6	49	0	141	142	0	28	28
2025	10	19	10	50	0	30.2	-2	1.03	0.4	0.3	0	49.5	49.5	0	142	143	0	27	28
2025	10	19	11	0	0	30.2	-0.6	1.03	0.5	0.4	0	46.9	47.7	0	137	139	0	28	28
2025	10	19	11	10	0	31.4	-1.8	1.03	0.4	0.3	0	46.4	46.9	0	136	137	0	28	28
2025	10	19	11	20	0	30.4	-1.5	1.03	0.5	0.4	0	46	46.9	0	135	137	0	28	28
2025	10	19	11	30	0	30.4	-1.5	1.029	0.5	0.4	0	46	47.3	0	135	137	0	28	27
2025	10	19	11	40	0	29.5	-1.5	1.029	0.5	0.4	0	46	46.9	0	135	137	0	28	28
2025	10	19	11	50	0	30	-2.5	1.029	0.3	0.2	0	46	46.4	0	135	136	0	28	28
2025	10	19	12	0	0	31.1	-2.1	1.027	0.5	0.4	0	46	46	0	134	136	0	27	29
2025	10	19	12	10	0	30.5	-2.8	1.025	0.4	0.3	0	46	46.4	0	135	136	0	28	28
2025	10	19	12	20	0	30.5	-2.2	1.025	0.4	0.3	0	46	46.9	0	134	136	0	27	27
2025	10	19	12	30	0	29.6	-2.2	1.025	0.4	0.3	0	46	46.4	0	134	136	0	27	28
2025	10	19	12	40	0	29.8	-1.5	1.024	0.5	0.5	0	46.4	46.9	0	136	137	0	28	28
2025	10	19	12	50	0	30.5	-1.8	1.024	0.4	0.3	0	46	46.9	0	135	137	0	28	28
2025	10	19	13	0	0	30.6	-2.1	1.024	0.5	0.4	0	46	47.3	0	135	137	0	28	27
2025	10	19	13	10	0	31	-2.6	1.025	0.3	0.2	0	46	47.3	0	135	137	0	28	27
2025	10	19	13	20	0	31	-1.5	1.023	0.4	0.3	0	46.4	47.3	0	136	137	0	28	27
2025	10	19	13	30	0	30.8	-1.7	1.024	0.4	0.3	0	46.9	46.9	0	136	137	0	27	28
2025	10	19	13	40	0	30.6	-2.7	1.023	0.4	0.3	0	46.9	47.3	0	137	138	0	28	28
2025	10	19	13	50	0	31.2	-1.2	1.022	0.3	0.2	0	46.9	46.9	0	136	137	0	27	28
2025	10	19	14	0	0	30.1	-2.1	1.022	0.5	0.4	0	46.9	47.3	0	136	138	0	27	28
2025	10	19	14	10	0	29.6	-2.2	1.021	0.4	0.3	0	46.9	46.9	0	136	137	0	27	28
2025	10	19	14	20	0	30	-1.8	1.021	0.4	0.3	0	46.9	47.3	0	136	138	0	27	28
2025	10	19	14	30	0	30.3	-2.7	1.021	0.4	0.3	0	46.4	47.3	0	136	138	0	28	28
2025	10	19	14	40	0	30.1	-2.2	1.02	0.5	0.4	0	46.4	46.9	0	135	137	0	27	28
2025	10	19	14	50	0	30.2	-1.2	1.019	0.3	0.2	0	46	47.3	0	135	137	0	28	27
2025	10	19	15	0	0	30.2	-2.3	1.018	0.5	0.5	0	46.4	47.3	0	136	138	0	28	28
2025	10	19	15	10	0	30.1	-2.1	1.019	0.4	0.3	0	46.9	46.9	0	136	137	0	27	28
2025	10	19	15	20	0	30.1	-2.4	1.016	0.5	0.4	0	46.4	46.9	0	135	137	0	27	28
2025	10	19	15	30	0	30.1	-2.4	1.016	0.5	0.4	0	46.9	46.9	0	136	137	0	27	28
2025	10	19	15	40	0	29.5	-2.5	1.016	0.4	0.3	0	46.9	47.7	0	136	138	0	27	27
2025	10	19	15	50	0	31	-2	1.016	0.5	0.4	0	46.9	47.7	0	136	138	0	27	27
2025	10	19	16	0	0	29.3	-2.6	1.015	0.4	0.3	0	46.4	47.7	0	136	138	0	28	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	19	16	10	0	30.6	-1.4	1.014	0.5	0.4	0	46.4	47.3	0	136	138	0	28	28
2025	10	19	16	20	0	30.2	-2.8	1.014	0.5	0.4	0	46	46.4	0	134	136	0	27	28
2025	10	19	16	30	0	30.6	-2.2	1.014	0.4	0.3	0	46.4	46.9	0	135	137	0	27	28
2025	10	19	16	40	0	30.6	-2.2	1.014	0.5	0.4	0	46	46.4	0	134	136	0	27	28
2025	10	19	16	50	0	30.6	-2.2	1.013	0.5	0.4	0	46.4	47.3	0	135	137	0	27	27
2025	10	19	17	0	0	29.2	-1.2	1.013	0.5	0.4	0	46.4	46.9	0	135	136	0	27	27
2025	10	19	17	10	0	30.4	-2.1	1.013	0.5	0.5	0	47.3	47.7	0	137	139	0	27	28
2025	10	19	17	20	0	30.2	-2	1.013	0.4	0.3	0	46.4	47.7	0	136	138	0	28	27
2025	10	19	17	30	0	29.5	-1.1	1.012	0.5	0.4	0	46	46.9	0	135	137	0	28	28
2025	10	19	17	40	0	29.7	-1.9	1.012	0.4	0.3	0	46.4	46.9	0	135	137	0	27	28
2025	10	19	17	50	0	30.3	-0.8	1.011	0.5	0.4	0	46	46.9	0	135	137	0	28	28
2025	10	19	18	0	0	29.8	-2.7	1.011	0.4	0.3	0	46	46.9	0	135	137	0	28	28
2025	10	19	18	10	0	29.8	-1.6	1.011	0.3	0.2	0	46.4	47.3	0	135	137	0	27	27
2025	10	19	18	20	0	30	-0.9	1.01	0.5	0.4	0	47.3	47.3	0	137	138	0	27	28
2025	10	19	18	30	0	29.2	-1.4	1.009	0.3	0.2	0	46.9	47.7	0	137	139	0	28	28
2025	10	19	18	40	0	28.8	-1.5	1.008	0.3	0.2	0	47.7	48.2	0	137	139	0	26	27
2025	10	19	18	50	0	29.9	-1.3	1.007	0.5	0.4	0	47.7	48.2	0	138	140	0	27	28
2025	10	19	19	0	0	29.9	-1.5	1.006	0.5	0.4	0	47.7	48.6	0	138	141	0	27	28
2025	10	19	19	10	0	29.5	-1.6	1.005	0.5	0.4	0	48.2	48.6	0	139	141	0	27	28
2025	10	19	19	20	0	29.4	-2.8	1.005	0.5	0.4	0	47.7	47.7	0	138	140	0	27	29
2025	10	19	19	30	0	29.5	-3.5	1.004	0.4	0.3	0	47.7	48.6	0	138	141	0	27	28
2025	10	19	19	40	0	29.9	-2.6	1.004	0.4	0.3	0	47.7	48.6	0	138	141	0	27	28
2025	10	19	19	50	0	28.9	-0.4	1.004	0.5	0.4	0	47.7	49.5	0	139	142	0	28	27
2025	10	19	20	0	0	28.9	-1.2	1.003	0.4	0.3	0	47.7	49.5	0	139	142	0	28	27
2025	10	19	20	10	0	28.8	-2	1.003	0.4	0.3	0	48.2	49	0	139	142	0	27	28
2025	10	19	20	20	0	29.1	-2.1	1.003	0.5	0.4	0	48.6	49.9	0	140	143	0	27	27
2025	10	19	20	30	0	29.3	-1.7	1.002	0.4	0.3	0	48.6	50.3	0	141	144	0	28	27
2025	10	19	20	40	0	29	-1.4	1.002	0.4	0.3	0	48.6	49.9	0	140	143	0	27	27
2025	10	19	20	50	0	29.5	-0.1	1.002	0.4	0.3	0	49	49.5	0	141	144	0	27	29
2025	10	19	21	0	0	29.5	-2.2	1.001	0.5	0.4	0	48.2	49.9	0	140	143	0	28	27
2025	10	19	21	10	0	27.9	-1.7	1.001	0.5	0.4	0	48.6	49.9	0	141	144	0	28	28
2025	10	19	21	20	0	29.2	-2.5	1.001	0.5	0.5	0	49	49.9	0	141	144	0	27	28
2025	10	19	21	30	0	29.1	-1.5	1.001	0.5	0.4	0	49	49.9	0	141	144	0	27	28
2025	10	19	21	40	0	28.8	-1.7	1	0.5	0.4	0	48.6	49.9	0	141	144	0	28	28
2025	10	19	21	50	0	28.4	-0.8	1	0.4	0.3	0	48.6	49.9	0	141	144	0	28	28
2025	10	19	22	0	0	29.5	-1.3	1	0.4	0.3	0	48.6	49.9	0	141	144	0	28	28
2025	10	19	22	10	0	30.2	-0.7	1	0.4	0.3	0	49	49.9	0	142	145	0	28	29
2025	10	19	22	20	0	28.5	-1.6	0.999	0.5	0.4	0	49.5	50.3	0	142	145	0	27	28
2025	10	19	22	30	0	30.3	-1.9	0.999	0.5	0.4	0	48.6	50.3	0	141	145	0	28	28
2025	10	19	22	40	0	29.6	-1.7	0.999	0.5	0.5	0	49	50.3	0	142	145	0	28	28
2025	10	19	22	50	0	28.7	-1.8	0.998	0.3	0.2	0	49.5	50.3	0	142	145	0	27	28
2025	10	19	23	0	0	29.1	-1.9	0.998	0.5	0.4	0	49	50.7	0	142	145	0	28	27
2025	10	19	23	10	0	28.5	-2.1	0.998	0.4	0.3	0	49	51.2	0	142	146	0	28	27
2025	10	19	23	20	0	28.3	-1.1	0.997	0.5	0.5	0	49.5	50.3	0	142	145	0	27	28
2025	10	19	23	30	0	27.8	-1.4	0.997	0.4	0.3	0	49	50.3	0	141	145	0	27	28
2025	10	19	23	40	0	28.6	-1.1	0.997	0.6	0.5	0	49	49.9	0	141	144	0	27	28
2025	10	19	23	50	0	28	-1.4	0.996	0.3	0.2	0	49.5	50.3	0	142	145	0	27	28
2025	10	20	0	0	0	28.6	-1.5	0.996	0.3	0.2	0	49.5	50.3	0	142	145	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	20	0	10	0	29	-2.1	0.995	0.4	0.3	0	49	50.7	0	142	145	0	28	27
2025	10	20	0	20	0	28.5	-1.6	0.995	0.4	0.3	0	49	50.7	0	142	145	0	28	27
2025	10	20	0	30	0	29.4	-1.6	0.994	0.5	0.4	0	49.9	50.7	0	143	146	0	27	28
2025	10	20	0	40	0	29.4	-1.5	0.994	0.4	0.3	0	49.5	50.7	0	142	146	0	27	28
2025	10	20	0	50	0	28.6	-1.9	0.993	0.4	0.3	0	49	50.3	0	142	146	0	28	29
2025	10	20	1	0	0	29.1	-1.9	0.992	0.5	0.5	0	49	50.7	0	142	146	0	28	28
2025	10	20	1	10	0	28.8	-2.4	0.991	0.5	0.5	0	49	50.7	0	142	146	0	28	28
2025	10	20	1	20	0	28.1	-1	0.991	0.5	0.4	0	49.5	51.2	0	142	147	0	27	28
2025	10	20	1	30	0	28.8	-1.4	0.99	0.4	0.3	0	49	50.7	0	142	146	0	28	28
2025	10	20	1	40	0	29.9	-1.6	0.99	0.5	0.4	0	49	51.2	0	142	146	0	28	27
2025	10	20	1	50	0	28.9	-1.2	0.99	0.4	0.3	0	49.5	50.7	0	142	146	0	27	28
2025	10	20	2	0	0	28.4	-1	0.989	0.4	0.3	0	49	50.7	0	142	146	0	28	28
2025	10	20	2	10	0	28.5	-2.1	0.989	0.5	0.5	0	49.5	51.2	0	143	147	0	28	28
2025	10	20	2	20	0	29.5	-2.3	0.989	0.5	0.4	0	49	51.2	0	142	147	0	28	28
2025	10	20	2	30	0	28.3	-2.4	0.989	0.5	0.4	0	49.5	51.6	0	142	147	0	27	27
2025	10	20	2	40	0	28	-1.7	0.988	0.4	0.3	0	49	50.7	0	142	146	0	28	28
2025	10	20	2	50	0	29.2	-1	0.988	0.5	0.4	0	49	50.7	0	142	146	0	28	28
2025	10	20	3	0	0	28.5	-1.2	0.988	0.4	0.3	0	49	50.7	0	141	146	0	27	28
2025	10	20	3	10	0	28.6	-1.4	0.988	0.5	0.5	0	49.5	50.7	0	142	146	0	27	28
2025	10	20	3	20	0	27.6	-1.9	0.988	0.5	0.4	0	48.6	50.7	0	141	146	0	28	28
2025	10	20	3	30	0	29.2	-1.2	0.988	0.5	0.5	0	49.5	50.3	0	142	146	0	27	29
2025	10	20	3	40	0	29.1	-2.9	0.988	0.5	0.4	0	48.6	50.7	0	141	146	0	28	28
2025	10	20	3	50	0	28.8	-1.2	0.987	0.3	0.2	0	48.6	50.7	0	141	146	0	28	28
2025	10	20	4	0	0	27.2	-2.3	0.987	0.5	0.4	0	49	50.7	0	141	146	0	27	28
2025	10	20	4	10	0	28.3	-1.7	0.987	0.4	0.3	0	49	51.2	0	141	146	0	27	27
2025	10	20	4	20	0	28.7	-2.2	0.987	0.4	0.3	0	48.6	50.3	0	140	146	0	27	29
2025	10	20	4	30	0	29	-2.6	0.987	0.4	0.3	0	49.9	50.7	0	143	146	0	27	28
2025	10	20	4	40	0	29.1	-2.1	0.987	0.4	0.3	0	49.9	50.7	0	143	146	0	27	28
2025	10	20	4	50	0	28.2	-2.3	0.987	0.5	0.4	0	49.9	51.2	0	143	146	0	27	27
2025	10	20	5	0	0	28.7	-1.4	0.986	0.3	0.2	0	49.5	51.2	0	143	146	0	28	27
2025	10	20	5	10	0	27.5	-1.7	0.986	0.4	0.3	0	49.9	50.7	0	143	146	0	27	28
2025	10	20	5	20	0	28.7	-1.2	0.986	0.4	0.3	0	49.5	50.7	0	143	146	0	28	28
2025	10	20	5	30	0	29	-2.1	0.986	0.5	0.4	0	49.9	50.7	0	143	146	0	27	28
2025	10	20	5	40	0	28.6	-2.2	0.986	0.3	0.2	0	49.5	50.7	0	143	146	0	28	28
2025	10	20	5	50	0	28.7	-2.1	0.986	0.6	0.5	0	49.5	50.7	0	143	146	0	28	28
2025	10	20	6	0	0	28.6	-0.6	0.986	0.4	0.3	0	49.5	50.7	0	143	146	0	28	28
2025	10	20	6	10	0	29.4	-1.9	0.986	0.3	0.2	0	49.9	50.3	0	143	146	0	27	29
2025	10	20	6	20	0	27.1	-1.6	0.986	0.6	0.5	0	49	50.3	0	142	146	0	28	29
2025	10	20	6	30	0	28.8	-1.5	0.986	0.5	0.4	0	49.9	51.2	0	143	147	0	27	28
2025	10	20	6	40	0	27.5	-1.7	0.985	0.5	0.4	0	49	50.7	0	143	146	0	29	28
2025	10	20	6	50	0	29.9	-2.3	0.985	0.5	0.4	0	49.5	50.7	0	142	146	0	27	28
2025	10	20	7	0	0	28.7	-2	0.985	0.5	0.4	0	49	50.7	0	142	146	0	28	28
2025	10	20	7	10	0	28.8	-2.5	0.985	0.4	0.3	0	49	50.7	0	142	146	0	28	28
2025	10	20	7	20	0	27.7	-1.9	0.985	0.3	0.2	0	49	50.3	0	141	145	0	27	28
2025	10	20	7	30	0	28.4	-1.7	0.985	0.4	0.3	0	48.6	49.9	0	141	144	0	28	28
2025	10	20	7	40	0	28.8	-2	0.985	0.5	0.4	0	48.2	49.9	0	140	144	0	28	28
2025	10	20	7	50	0	28.7	-1.9	0.985	0.5	0.4	0	48.2	49.9	0	139	143	0	27	27
2025	10	20	8	0	0	28.4	-2.4	0.985	0.5	0.4	0	48.2	49.5	0	140	143	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	20	8	10	0	29.2	-1.9	0.985	0.5	0.4	0	48.2	49.9	0	140	144	0	28	28
2025	10	20	8	20	0	28.3	-0.7	0.985	0.5	0.5	0	47.7	49.5	0	139	143	0	28	28
2025	10	20	8	30	0	27.5	-1.7	0.984	0.3	0.2	0	47.3	49	0	138	142	0	28	28
2025	10	20	8	40	0	29.5	-1.8	0.984	0.5	0.4	0	47.3	49	0	138	142	0	28	28
2025	10	20	8	50	0	28	-0.8	0.984	0.5	0.4	0	47.3	49	0	138	142	0	28	28
2025	10	20	9	0	0	28.1	-1.6	0.984	0.3	0.2	0	47.7	49	0	138	142	0	27	28
2025	10	20	9	10	0	28.3	-1.3	0.984	0.5	0.4	0	46.9	48.2	0	137	140	0	28	28
2025	10	20	9	20	0	28.6	-1.6	0.984	0.4	0.3	0	46.4	48.2	0	136	140	0	28	28
2025	10	20	9	30	0	27.2	-1.2	0.984	0.3	0.2	0	46.9	48.2	0	136	140	0	27	28
2025	10	20	9	40	0	27.6	-1.4	0.984	0.5	0.4	0	46.4	48.2	0	136	140	0	28	28
2025	10	20	9	50	0	27.7	-1.7	0.984	0.5	0.4	0	46.4	48.2	0	136	140	0	28	28
2025	10	20	10	0	0	28.3	-1.9	0.984	0.3	0.2	0	46	47.3	0	135	139	0	28	29
2025	10	20	10	10	0	28.2	-1.3	0.983	0.4	0.3	0	46	47.3	0	135	138	0	28	28
2025	10	20	10	20	0	28.3	-2	0.983	0.5	0.4	0	46.4	47.3	0	135	138	0	27	28
2025	10	20	10	30	0	28.2	-1.3	0.983	0.3	0.2	0	46.9	48.2	0	137	140	0	28	28
2025	10	20	10	40	0	27.4	-1.3	0.983	0.5	0.5	0	46.4	48.2	0	136	140	0	28	28
2025	10	20	10	50	0	28.2	-2.8	0.983	0.4	0.3	0	46.9	48.6	0	137	141	0	28	28
2025	10	20	11	0	0	27.6	-1.7	0.983	0.4	0.3	0	46.4	48.2	0	136	140	0	28	28
2025	10	20	11	10	0	28.2	-2.9	0.982	0.4	0.3	0	46.9	47.7	0	136	139	0	27	28
2025	10	20	11	20	0	28.4	-1.7	0.982	0.4	0.3	0	46.4	48.2	0	136	139	0	28	27
2025	10	20	11	30	0	28.3	-1.7	0.981	0.5	0.4	0	46	47.7	0	135	139	0	28	28
2025	10	20	11	40	0	28.1	-1.7	0.98	0.4	0.3	0	46.9	48.2	0	137	140	0	28	28
2025	10	20	11	50	0	27.5	-1.7	0.98	0.5	0.5	0	46	47.7	0	135	139	0	28	28
2025	10	20	12	0	0	27.7	-1.1	0.979	0.5	0.5	0	46.4	48.2	0	135	140	0	27	28
2025	10	20	12	10	0	27.7	-2.2	0.979	0.5	0.4	0	46.4	47.7	0	135	139	0	27	28
2025	10	20	12	20	0	27.6	-1.5	0.979	0.5	0.5	0	46.9	47.7	0	136	139	0	27	28
2025	10	20	12	30	0	28.2	-1.8	0.979	0.5	0.5	0	46.4	47.7	0	135	139	0	27	28
2025	10	20	12	40	0	27.5	-1.6	0.979	0.4	0.3	0	46.4	47.3	0	135	138	0	27	28
2025	10	20	12	50	0	28.4	-1	0.979	0.4	0.3	0	45.2	46.9	0	133	137	0	28	28
2025	10	20	13	0	0	28.4	-2.1	0.979	0.5	0.4	0	45.6	46.4	0	133	136	0	27	28
2025	10	20	13	10	0	28	-1.7	0.979	0.3	0.2	0	46.4	47.3	0	135	138	0	27	28
2025	10	20	13	20	0	28.4	-2.3	0.979	0.5	0.5	0	45.6	46.9	0	134	137	0	28	28
2025	10	20	13	30	0	27.9	-1.1	0.979	0.5	0.4	0	45.6	46.4	0	133	136	0	27	28
2025	10	20	13	40	0	27.9	-1.1	0.979	0.4	0.3	0	45.6	46.9	0	133	137	0	27	28
2025	10	20	13	50	0	27.7	-1.4	0.979	0.4	0.3	0	45.6	46.9	0	133	137	0	27	28
2025	10	20	14	0	0	29.3	-3	0.979	0.3	0.2	0	45.2	46.9	0	133	137	0	28	28
2025	10	20	14	10	0	27.9	-1.6	0.979	0.5	0.4	0	45.6	47.3	0	134	138	0	28	28
2025	10	20	14	20	0	28	-1.5	0.979	0.3	0.2	0	45.6	47.7	0	134	138	0	28	27
2025	10	20	14	30	0	27.8	-1.3	0.979	0.5	0.4	0	45.6	47.3	0	134	138	0	28	28
2025	10	20	14	40	0	26.9	-0.8	0.979	0.4	0.3	0	46.4	48.2	0	135	139	0	27	27
2025	10	20	14	50	0	28.1	-2.2	0.979	0.3	0.2	0	46.4	47.3	0	135	138	0	27	28
2025	10	20	15	0	0	28.4	-1.2	0.979	0.5	0.4	0	46	47.3	0	135	138	0	28	28
2025	10	20	15	10	0	28.2	-2.5	0.979	0.5	0.5	0	46.4	47.3	0	135	138	0	27	28
2025	10	20	15	20	0	28.3	-1.8	0.979	0.5	0.4	0	46.4	47.7	0	135	139	0	27	28
2025	10	20	15	30	0	27.7	-1.8	0.978	0.4	0.3	0	46.4	47.3	0	135	138	0	27	28
2025	10	20	15	40	0	28.1	-1.1	0.978	0.5	0.4	0	46	48.2	0	135	139	0	28	27
2025	10	20	15	50	0	27.8	-1.6	0.978	0.5	0.4	0	46.4	47.7	0	135	139	0	27	28
2025	10	20	16	0	0	29.3	-1.3	0.978	0.5	0.5	0	46.4	48.2	0	136	140	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	20	16	10	0	28.5	-2.6	0.978	0.5	0.4	0	47.3	48.6	0	136	140	0	26	27
2025	10	20	16	20	0	29.3	-3.1	0.978	0.4	0.3	0	46.9	48.2	0	136	140	0	27	28
2025	10	20	16	30	0	28.8	-2.5	0.978	0.3	0.2	0	46.9	48.2	0	136	140	0	27	28
2025	10	20	16	40	0	28.3	-3	0.978	0.5	0.5	0	46.9	48.2	0	136	140	0	27	28
2025	10	20	16	50	0	28.8	-2.6	0.978	0.5	0.4	0	46.9	48.6	0	136	141	0	27	28
2025	10	20	17	0	0	27.4	-2.3	0.977	0.3	0.2	0	47.3	49	0	138	142	0	28	28
2025	10	20	17	10	0	29	-1	0.977	0.3	0.2	0	47.7	49	0	138	142	0	27	28
2025	10	20	17	20	0	27.7	-2.3	0.977	0.5	0.4	0	47.7	49.5	0	138	142	0	27	27
2025	10	20	17	30	0	27.3	-1.1	0.977	0.5	0.4	0	47.7	49	0	138	142	0	27	28
2025	10	20	17	40	0	27.6	-1.6	0.977	0.4	0.3	0	47.3	49.5	0	138	142	0	28	27
2025	10	20	17	50	0	28.8	-1.7	0.977	0.4	0.3	0	47.7	49.5	0	138	142	0	27	27
2025	10	20	18	0	0	28.3	-1.9	0.977	0.6	0.5	0	47.7	49.5	0	138	142	0	27	27
2025	10	20	18	10	0	28.5	-2	0.977	0.5	0.5	0	47.7	49	0	138	142	0	27	28
2025	10	20	18	20	0	27.9	-1.3	0.976	0.5	0.4	0	48.2	49.9	0	139	143	0	27	27
2025	10	20	18	30	0	28.9	-2.4	0.977	0.5	0.4	0	47.3	49.5	0	138	142	0	28	27
2025	10	20	18	40	0	27.9	-0.8	0.977	0.5	0.5	0	47.3	49.9	0	138	143	0	28	27
2025	10	20	18	50	0	28.1	-2.4	0.976	0.5	0.5	0	48.2	49.5	0	139	143	0	27	28
2025	10	20	19	0	0	27.6	-2.2	0.976	0.4	0.3	0	48.6	49.9	0	140	144	0	27	28
2025	10	20	19	10	0	27.1	-1.9	0.976	0.5	0.4	0	48.6	49.9	0	140	144	0	27	28
2025	10	20	19	20	0	28.1	-0.1	0.976	0.5	0.5	0	49	50.3	0	141	145	0	27	28
2025	10	20	19	30	0	27.5	-1.3	0.976	0.5	0.4	0	48.6	50.3	0	140	145	0	27	28
2025	10	20	19	40	0	28.5	-1.2	0.976	0.4	0.3	0	49	50.7	0	141	145	0	27	27
2025	10	20	19	50	0	27.4	-2	0.976	0.4	0.3	0	49	50.3	0	141	145	0	27	28
2025	10	20	20	0	0	28.4	-1.1	0.976	0.5	0.4	0	49	51.2	0	142	146	0	28	27
2025	10	20	20	10	0	28.2	-1.7	0.975	0.3	0.2	0	49.5	51.6	0	142	147	0	27	27
2025	10	20	20	20	0	28.2	-1.3	0.975	0.4	0.3	0	49.5	51.2	0	142	146	0	27	27
2025	10	20	20	30	0	27.7	-1.2	0.975	0.5	0.5	0	49.5	50.7	0	142	146	0	27	28
2025	10	20	20	40	0	29.1	-1	0.975	0.5	0.4	0	49.5	51.2	0	142	146	0	27	27
2025	10	20	20	50	0	27.7	-1.5	0.975	0.5	0.4	0	49.9	51.6	0	143	147	0	27	27
2025	10	20	21	0	0	26.9	-2.1	0.975	0.5	0.4	0	49.9	51.2	0	143	147	0	27	28
2025	10	20	21	10	0	28.6	-2.3	0.975	0.5	0.5	0	49.5	51.2	0	142	147	0	27	28
2025	10	20	21	20	0	26.6	-1.6	0.974	0.5	0.5	0	50.3	51.2	0	144	147	0	27	28
2025	10	20	21	30	0	28.8	-1.7	0.974	0.4	0.3	0	50.7	51.2	0	145	147	0	27	28
2025	10	20	21	40	0	27	-1.3	0.974	0.5	0.4	0	50.7	51.6	0	145	148	0	27	28
2025	10	20	21	50	0	28.4	-1.9	0.974	0.5	0.4	0	50.7	51.2	0	145	147	0	27	28
2025	10	20	22	0	0	27.2	-2	0.974	0.5	0.4	0	50.7	52	0	145	148	0	27	27
2025	10	20	22	10	0	27.6	-2.2	0.974	0.4	0.3	0	50.7	51.2	0	145	147	0	27	28
2025	10	20	22	20	0	27.6	-1.5	0.974	0.4	0.3	0	51.2	52	0	146	148	0	27	27
2025	10	20	22	30	0	27.9	-1.7	0.974	0.4	0.3	0	51.2	52	0	146	148	0	27	27
2025	10	20	22	40	0	28	-2.5	0.974	0.5	0.4	0	50.7	52	0	145	148	0	27	27
2025	10	20	22	50	0	27.5	-0.9	0.974	0.5	0.4	0	51.2	52.5	0	146	149	0	27	27
2025	10	20	23	0	0	26.8	-1.7	0.973	0.4	0.3	0	51.2	51.6	0	146	148	0	27	28
2025	10	20	23	10	0	27.8	-1.3	0.973	0.5	0.4	0	50.7	52	0	146	148	0	28	27
2025	10	20	23	20	0	27.6	-1.8	0.973	0.5	0.4	0	50.7	51.6	0	145	148	0	27	28
2025	10	20	23	30	0	27.5	-1.7	0.973	0.5	0.4	0	50.7	52	0	146	149	0	28	28
2025	10	20	23	40	0	27.7	-2.7	0.973	0.5	0.4	0	50.7	51.6	0	145	148	0	27	28
2025	10	20	23	50	0	27.7	-2.2	0.973	0.5	0.4	0	50.3	51.6	0	145	148	0	28	28
2025	10	21	0	0	0	27.9	-1.3	0.973	0.5	0.5	0	50.7	51.6	0	145	148	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	21	0	10	0	28.7	-1.8	0.973	0.5	0.4	0	50.7	51.6	0	145	148	0	27	28
2025	10	21	0	20	0	27.4	-1.4	0.973	0.5	0.4	0	50.3	52	0	145	149	0	28	28
2025	10	21	0	30	0	28.3	-1.7	0.973	0.5	0.4	0	50.3	52.5	0	145	149	0	28	27
2025	10	21	0	40	0	27.7	-1.7	0.973	0.5	0.4	0	50.7	51.6	0	145	148	0	27	28
2025	10	21	0	50	0	27.3	-1.8	0.973	0.5	0.4	0	50.7	52	0	145	148	0	27	27
2025	10	21	1	0	0	27.1	-1.8	0.972	0.5	0.4	0	50.7	51.6	0	145	148	0	27	28
2025	10	21	1	10	0	27	-2.1	0.972	0.6	0.5	0	50.3	51.6	0	145	148	0	28	28
2025	10	21	1	20	0	27.1	-2.3	0.972	0.5	0.4	0	50.3	51.6	0	144	148	0	27	28
2025	10	21	1	30	0	27.3	-0.7	0.972	0.4	0.3	0	50.3	52	0	145	149	0	28	28
2025	10	21	1	40	0	27.5	-1.4	0.972	0.6	0.5	0	50.7	52	0	145	149	0	27	28
2025	10	21	1	50	0	28.2	-1.7	0.972	0.5	0.4	0	50.3	51.6	0	144	148	0	27	28
2025	10	21	2	0	0	27.7	-1.4	0.972	0.4	0.3	0	50.3	52.5	0	145	149	0	28	27
2025	10	21	2	10	0	27.5	-2.1	0.972	0.5	0.4	0	49.9	51.6	0	144	148	0	28	28
2025	10	21	2	20	0	26.6	-0.9	0.972	0.5	0.4	0	50.3	52	0	144	149	0	27	28
2025	10	21	2	30	0	27.6	-2.5	0.971	0.4	0.3	0	49.9	51.6	0	144	148	0	28	28
2025	10	21	2	40	0	27	-0.4	0.972	0.4	0.3	0	50.3	51.6	0	144	148	0	27	28
2025	10	21	2	50	0	28.4	-1.2	0.972	0.4	0.3	0	50.3	51.6	0	144	148	0	27	28
2025	10	21	3	0	0	27	-1.4	0.971	0.4	0.3	0	50.3	51.6	0	144	148	0	27	28
2025	10	21	3	10	0	27.3	-1.2	0.971	0.5	0.4	0	50.3	51.6	0	145	148	0	28	28
2025	10	21	3	20	0	28.2	-2.8	0.971	0.5	0.4	0	50.3	51.6	0	144	148	0	27	28
2025	10	21	3	30	0	27.2	-2.6	0.971	0.5	0.5	0	49.9	51.6	0	144	148	0	28	28
2025	10	21	3	40	0	27.1	-1.5	0.971	0.3	0.2	0	50.3	52	0	144	148	0	27	27
2025	10	21	3	50	0	27.4	-2.1	0.971	0.5	0.5	0	49.9	51.6	0	144	149	0	28	29
2025	10	21	4	0	0	27.5	-1.3	0.971	0.6	0.5	0	50.7	52.5	0	145	149	0	27	27
2025	10	21	4	10	0	28.6	-1.4	0.97	0.5	0.5	0	49.9	51.6	0	144	148	0	28	28
2025	10	21	4	20	0	27.2	-2.9	0.971	0.5	0.5	0	50.3	52	0	144	149	0	27	28
2025	10	21	4	30	0	27.6	-2.1	0.971	0.5	0.4	0	50.3	51.6	0	144	148	0	27	28
2025	10	21	4	40	0	27.3	-1.3	0.971	0.4	0.3	0	50.3	51.6	0	144	148	0	27	28
2025	10	21	4	50	0	28.6	-1.9	0.97	0.5	0.4	0	50.3	52	0	145	149	0	28	28
2025	10	21	5	0	0	27.9	-1.3	0.971	0.3	0.2	0	50.3	51.6	0	144	148	0	27	28
2025	10	21	5	10	0	27.6	-1	0.971	0.4	0.3	0	49.9	51.6	0	144	148	0	28	28
2025	10	21	5	20	0	26.3	-2.4	0.97	0.5	0.4	0	49.9	51.6	0	144	148	0	28	28
2025	10	21	5	30	0	27.2	-0.9	0.97	0.4	0.3	0	49.9	52	0	144	149	0	28	28
2025	10	21	5	40	0	27.5	-1.9	0.97	0.5	0.4	0	50.3	51.6	0	144	148	0	27	28
2025	10	21	5	50	0	28	-2.1	0.97	0.5	0.4	0	50.3	51.6	0	144	148	0	27	28
2025	10	21	6	0	0	26.3	-2.4	0.97	0.3	0.2	0	49.9	52	0	144	149	0	28	28
2025	10	21	6	10	0	27.7	-2.3	0.97	0.4	0.3	0	49.9	52	0	144	149	0	28	28
2025	10	21	6	20	0	27.1	-0.8	0.97	0.4	0.3	0	49.9	52	0	144	149	0	28	28
2025	10	21	6	30	0	27.3	-2.2	0.97	0.4	0.3	0	49.9	52.5	0	144	149	0	28	27
2025	10	21	6	40	0	27.4	-2.3	0.97	0.4	0.3	0	50.3	52	0	144	149	0	27	28
2025	10	21	6	50	0	28	-1.9	0.97	0.5	0.4	0	50.3	51.6	0	144	148	0	27	28
2025	10	21	7	0	0	27	-2.2	0.97	0.5	0.4	0	49.9	51.6	0	144	148	0	28	28
2025	10	21	7	10	0	26.4	-3	0.97	0.4	0.3	0	49.5	51.6	0	143	148	0	28	28
2025	10	21	7	20	0	27.4	-2.3	0.97	0.4	0.3	0	49.9	51.2	0	144	148	0	28	29
2025	10	21	7	30	0	28.4	-2	0.97	0.5	0.4	0	49.5	51.2	0	143	147	0	28	28
2025	10	21	7	40	0	28.8	-2.2	0.97	0.5	0.4	0	49.5	51.2	0	143	147	0	28	28
2025	10	21	7	50	0	26.6	-2.1	0.97	0.4	0.3	0	49.5	51.2	0	142	147	0	27	28
2025	10	21	8	0	0	28	-2	0.97	0.4	0.3	0	49	51.2	0	142	147	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	21	8	10	0	27	-1.6	0.97	0.5	0.4	0	49.5	51.2	0	142	147	0	27	28
2025	10	21	8	20	0	27.9	-1.7	0.97	0.4	0.3	0	49.5	50.7	0	142	146	0	27	28
2025	10	21	8	30	0	27.5	-1.9	0.97	0.5	0.4	0	49	51.2	0	142	147	0	28	28
2025	10	21	8	40	0	27.7	-1.3	0.97	0.4	0.3	0	49.5	50.7	0	142	146	0	27	28
2025	10	21	8	50	0	28.3	-1.7	0.969	0.5	0.5	0	49.9	50.3	0	144	145	0	28	28
2025	10	21	9	0	0	27.4	-1.7	0.969	0.5	0.5	0	49.5	50.3	0	143	145	0	28	28
2025	10	21	9	10	0	27.8	-1.9	0.969	0.4	0.3	0	49.9	50.7	0	143	146	0	27	28
2025	10	21	9	20	0	28.8	-2.2	0.969	0.5	0.5	0	49.5	50.3	0	142	145	0	27	28
2025	10	21	9	30	0	27.7	-1.3	0.968	0.5	0.4	0	49	49.9	0	142	144	0	28	28
2025	10	21	9	40	0	28	-1.7	0.969	0.4	0.3	0	49.5	50.3	0	142	145	0	27	28
2025	10	21	9	50	0	26.7	-2.5	0.968	0.5	0.4	0	49.5	50.3	0	142	145	0	27	28
2025	10	21	10	0	0	28.7	-2	0.968	0.5	0.5	0	49	50.3	0	142	144	0	28	27
2025	10	21	10	10	0	27.5	-1.7	0.968	0.4	0.3	0	49	49.9	0	142	144	0	28	28
2025	10	21	10	20	0	27.2	-1.4	0.968	0.3	0.2	0	49	49.9	0	141	144	0	27	28
2025	10	21	10	30	0	28.1	-1.9	0.967	0.4	0.3	0	49	49.9	0	141	144	0	27	28
2025	10	21	10	40	0	28.5	-1.6	0.968	0.5	0.5	0	49	49.5	0	141	143	0	27	28
2025	10	21	10	50	0	27.8	-1.7	0.968	0.5	0.4	0	49.5	49.9	0	142	144	0	27	28
2025	10	21	11	0	0	27	-2.6	0.968	0.5	0.5	0	48.6	49.9	0	141	144	0	28	28
2025	10	21	11	10	0	26.3	-2	0.968	0.4	0.3	0	48.6	49.5	0	140	143	0	27	28
2025	10	21	11	20	0	27.3	-1.8	0.968	0.5	0.4	0	48.6	49.5	0	140	143	0	27	28
2025	10	21	11	30	0	27.4	-2.3	0.968	0.5	0.5	0	48.2	49	0	140	142	0	28	28
2025	10	21	11	40	0	26.7	-2.2	0.968	0.5	0.4	0	48.6	49	0	140	142	0	27	28
2025	10	21	11	50	0	26.5	-0.9	0.968	0.5	0.5	0	48.2	49.5	0	140	143	0	28	28
2025	10	21	12	0	0	27.7	-1.9	0.968	0.5	0.4	0	48.2	49	0	139	142	0	27	28
2025	10	21	12	10	0	28.7	-1.7	0.968	0.5	0.4	0	46.9	47.7	0	136	139	0	27	28
2025	10	21	12	20	0	27.5	-2.5	0.968	0.4	0.3	0	46	47.3	0	135	138	0	28	28
2025	10	21	12	30	0	28.8	-2.1	0.968	0.5	0.4	0	46	47.3	0	135	138	0	28	28
2025	10	21	12	40	0	28.2	-2.4	0.968	0.5	0.5	0	46.4	47.3	0	136	138	0	28	28
2025	10	21	12	50	0	26.5	-2.2	0.968	0.3	0.2	0	46.9	47.7	0	136	139	0	27	28
2025	10	21	13	0	0	27.5	-2.5	0.968	0.5	0.4	0	46.4	47.7	0	136	139	0	28	28
2025	10	21	13	10	0	27.8	-1.8	0.968	0.5	0.4	0	46.9	47.3	0	135	138	0	26	28
2025	10	21	13	20	0	27.3	-1.2	0.968	0.6	0.5	0	46.4	47.3	0	135	138	0	27	28
2025	10	21	13	30	0	28.4	-1.9	0.968	0.5	0.5	0	46	47.3	0	135	138	0	28	28
2025	10	21	13	40	0	27.8	-1.5	0.968	0.4	0.3	0	45.6	47.3	0	134	138	0	28	28
2025	10	21	13	50	0	27.6	-1.4	0.968	0.5	0.4	0	46	46.9	0	134	137	0	27	28
2025	10	21	14	0	0	28.4	-1.9	0.968	0.5	0.4	0	46	46.9	0	134	137	0	27	28
2025	10	21	14	10	0	28	-1.8	0.968	0.5	0.5	0	46	46.9	0	134	137	0	27	28
2025	10	21	14	20	0	27.7	-1.7	0.968	0.5	0.4	0	46.4	47.7	0	135	138	0	27	27
2025	10	21	14	30	0	27.7	-1.2	0.968	0.5	0.4	0	46	47.3	0	134	137	0	27	27
2025	10	21	14	40	0	27.8	-1.3	0.968	0.4	0.3	0	46	47.7	0	134	138	0	27	27
2025	10	21	14	50	0	27.9	-0.9	0.968	0.3	0.2	0	46.4	47.3	0	135	138	0	27	28
2025	10	21	15	0	0	27	-1.5	0.968	0.4	0.3	0	46.4	47.7	0	135	139	0	27	28
2025	10	21	15	10	0	28	-0.9	0.968	0.4	0.3	0	46.4	47.7	0	135	138	0	27	27
2025	10	21	15	20	0	27.9	-1.1	0.968	0.4	0.3	0	46.4	47.3	0	135	138	0	27	28
2025	10	21	15	30	0	27.4	-2.2	0.968	0.5	0.4	0	46.4	47.7	0	135	139	0	27	28
2025	10	21	15	40	0	27.1	-1.9	0.968	0.4	0.3	0	46.9	48.2	0	136	140	0	27	28
2025	10	21	15	50	0	27.2	-1.8	0.968	0.5	0.5	0	46.4	48.2	0	136	140	0	28	28
2025	10	21	16	0	0	27.7	-1.7	0.968	0.4	0.3	0	46.9	47.7	0	136	139	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	21	16	10	0	27.9	-2.1	0.968	0.3	0.2	0	46.9	48.2	0	136	139	0	27	27
2025	10	21	16	20	0	26.9	-1.7	0.968	0.5	0.4	0	46.4	48.2	0	135	139	0	27	27
2025	10	21	16	30	0	28	-1.4	0.968	0.3	0.2	0	46	47.7	0	135	139	0	28	28
2025	10	21	16	40	0	27.4	-1.8	0.967	0.5	0.5	0	46.4	48.6	0	136	140	0	28	27
2025	10	21	16	50	0	28	-1.4	0.967	0.5	0.4	0	47.3	48.2	0	137	140	0	27	28
2025	10	21	17	0	0	27.5	-1.9	0.967	0.5	0.4	0	47.3	49	0	138	141	0	28	27
2025	10	21	17	10	0	27.7	-1.8	0.967	0.5	0.4	0	47.3	48.6	0	137	141	0	27	28
2025	10	21	17	20	0	26.9	-1.5	0.968	0.5	0.4	0	47.7	49	0	138	142	0	27	28
2025	10	21	17	30	0	27.2	-1.5	0.968	0.5	0.5	0	48.2	49.5	0	139	143	0	27	28
2025	10	21	17	40	0	27	-2.6	0.968	0.4	0.3	0	48.2	49.9	0	139	143	0	27	27
2025	10	21	17	50	0	26.4	-2	0.967	0.5	0.5	0	47.7	49.5	0	138	143	0	27	28
2025	10	21	18	0	0	27	-2.1	0.967	0.5	0.4	0	47.7	49.5	0	139	143	0	28	28
2025	10	21	18	10	0	27.6	-1	0.968	0.4	0.3	0	48.2	49.5	0	139	143	0	27	28
2025	10	21	18	20	0	28.3	-2.1	0.967	0.5	0.4	0	48.2	49.9	0	139	143	0	27	27
2025	10	21	18	30	0	28.3	-2.2	0.967	0.4	0.3	0	48.6	49.9	0	140	144	0	27	28
2025	10	21	18	40	0	28.2	-1.3	0.967	0.5	0.4	0	48.2	50.3	0	139	144	0	27	27
2025	10	21	18	50	0	27.5	-1.6	0.967	0.5	0.4	0	48.6	50.7	0	140	145	0	27	27
2025	10	21	19	0	0	27.5	-1.8	0.967	0.5	0.4	0	48.6	50.3	0	140	145	0	27	28
2025	10	21	19	10	0	27.1	-1.6	0.967	0.5	0.4	0	49	50.7	0	141	145	0	27	27
2025	10	21	19	20	0	27.3	-1.3	0.967	0.5	0.5	0	49	50.3	0	141	145	0	27	28
2025	10	21	19	30	0	27.9	-1.7	0.967	0.5	0.5	0	48.6	50.3	0	140	145	0	27	28
2025	10	21	19	40	0	27	-1.5	0.967	0.5	0.5	0	49	51.2	0	141	146	0	27	27
2025	10	21	19	50	0	26.7	-1.7	0.967	0.5	0.5	0	49	50.7	0	141	146	0	27	28
2025	10	21	20	0	0	26.7	-1.8	0.967	0.6	0.5	0	49	50.7	0	141	146	0	27	28
2025	10	21	20	10	0	27.5	-1.7	0.967	0.5	0.4	0	49	51.6	0	141	147	0	27	27
2025	10	21	20	20	0	25.8	-1.3	0.967	0.5	0.4	0	49.5	52	0	142	147	0	27	26
2025	10	21	20	30	0	27.4	-2.1	0.966	0.5	0.4	0	49	51.2	0	141	146	0	27	27
2025	10	21	20	40	0	26.6	-1.5	0.967	0.5	0.4	0	48.6	50.7	0	141	146	0	28	28
2025	10	21	20	50	0	27.6	-1.3	0.966	0.5	0.4	0	49.5	51.2	0	142	147	0	27	28
2025	10	21	21	0	0	27.4	-1.7	0.966	0.5	0.4	0	48.2	51.2	0	140	146	0	28	27
2025	10	21	21	10	0	26.7	-1.5	0.966	0.5	0.5	0	49.5	51.6	0	142	147	0	27	27
2025	10	21	21	20	0	27.2	-1.2	0.966	0.5	0.5	0	49.5	51.2	0	142	147	0	27	28
2025	10	21	21	30	0	26.9	-1.8	0.966	0.5	0.4	0	48.6	51.6	0	141	147	0	28	27
2025	10	21	21	40	0	26.8	-1.6	0.966	0.5	0.4	0	49	51.6	0	142	147	0	28	27
2025	10	21	21	50	0	27.9	-2.2	0.966	0.4	0.3	0	49.5	51.6	0	142	147	0	27	27
2025	10	21	22	0	0	27.3	-1.1	0.966	0.5	0.4	0	49.5	51.2	0	142	148	0	27	29
2025	10	21	22	10	0	26.9	-1.7	0.966	0.5	0.4	0	49.5	52	0	142	148	0	27	27
2025	10	21	22	20	0	26.8	-0.9	0.966	0.5	0.4	0	49.9	51.2	0	143	148	0	27	29
2025	10	21	22	30	0	27.8	-1	0.966	0.4	0.3	0	49	51.6	0	142	147	0	28	27
2025	10	21	22	40	0	26.6	-2.6	0.966	0.5	0.5	0	49.5	51.2	0	142	147	0	27	28
2025	10	21	22	50	0	26.3	-2.2	0.966	0.4	0.3	0	49.5	51.6	0	142	148	0	27	28
2025	10	21	23	0	0	28.1	-2.1	0.965	0.5	0.4	0	49.5	51.6	0	142	148	0	27	28
2025	10	21	23	10	0	27.2	-1.7	0.965	0.5	0.4	0	49	52	0	142	148	0	28	27
2025	10	21	23	20	0	28.9	-1.6	0.965	0.4	0.3	0	49	51.6	0	142	148	0	28	28
2025	10	21	23	30	0	26.4	-1.7	0.965	0.5	0.4	0	49.5	51.6	0	142	148	0	27	28
2025	10	21	23	40	0	27.2	-1.6	0.965	0.5	0.4	0	49.5	51.6	0	142	148	0	27	28
2025	10	21	23	50	0	27.3	-1.5	0.965	0.4	0.3	0	49.5	52	0	142	148	0	27	27
2025	10	22	0	0	0	26.7	-1.3	0.965	0.5	0.4	0	49.5	51.6	0	142	148	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	22	0	10	0	26.8	-1.5	0.965	0.5	0.4	0	49	51.6	0	141	148	0	27	28
2025	10	22	0	20	0	27.1	-1.9	0.965	0.4	0.3	0	48.6	51.6	0	142	148	0	29	28
2025	10	22	0	30	0	27.1	-1.7	0.965	0.5	0.5	0	49	52	0	142	148	0	28	27
2025	10	22	0	40	0	27.2	-1.5	0.965	0.5	0.4	0	49	51.6	0	142	148	0	28	28
2025	10	22	0	50	0	28.8	-2.8	0.965	0.5	0.5	0	49.5	52	0	142	148	0	27	27
2025	10	22	1	0	0	26.1	-0.9	0.965	0.5	0.4	0	49.5	52	0	142	149	0	27	28
2025	10	22	1	10	0	28	-1.8	0.965	0.5	0.4	0	48.6	52	0	141	148	0	28	27
2025	10	22	1	20	0	27.1	-0.9	0.965	0.5	0.4	0	49	52	0	142	149	0	28	28
2025	10	22	1	30	0	27.6	-1.7	0.965	0.4	0.3	0	49.5	52	0	142	148	0	27	27
2025	10	22	1	40	0	27.9	-0.6	0.965	0.5	0.4	0	49.5	51.2	0	142	148	0	27	29
2025	10	22	1	50	0	27.4	-1.6	0.964	0.4	0.3	0	49.5	52	0	143	149	0	28	28
2025	10	22	2	0	0	26.8	-2.8	0.965	0.4	0.3	0	49	51.6	0	142	148	0	28	28
2025	10	22	2	10	0	26.7	-1.4	0.964	0.5	0.4	0	49.9	52	0	143	149	0	27	28
2025	10	22	2	20	0	27.1	-1.9	0.964	0.5	0.4	0	49.5	52	0	143	149	0	28	28
2025	10	22	2	30	0	28.2	-1.4	0.965	0.5	0.4	0	49	51.6	0	142	148	0	28	28
2025	10	22	2	40	0	26.6	-1.6	0.964	0.5	0.4	0	49.9	52.5	0	143	149	0	27	27
2025	10	22	2	50	0	28.2	-0.6	0.964	0.5	0.4	0	49.9	52	0	143	149	0	27	28
2025	10	22	3	0	0	26.1	-1.6	0.964	0.5	0.5	0	49.9	52.5	0	144	150	0	28	28
2025	10	22	3	10	0	27	-1.7	0.964	0.5	0.4	0	49.9	52.5	0	143	149	0	27	27
2025	10	22	3	20	0	28.5	-1.7	0.964	0.5	0.5	0	49.9	52	0	143	149	0	27	28
2025	10	22	3	30	0	27.9	-2.1	0.964	0.5	0.4	0	49.9	52.5	0	143	149	0	27	27
2025	10	22	3	40	0	27.5	-1.7	0.964	0.5	0.5	0	49.9	52.9	0	143	150	0	27	27
2025	10	22	3	50	0	27.3	-2.2	0.964	0.4	0.3	0	49.9	52	0	143	149	0	27	28
2025	10	22	4	0	0	28	-2.9	0.964	0.5	0.4	0	49.5	52.5	0	143	150	0	28	28
2025	10	22	4	10	0	28.5	-0.9	0.964	0.4	0.3	0	50.3	52.5	0	144	150	0	27	28
2025	10	22	4	20	0	27.8	-3	0.964	0.5	0.5	0	49.9	52	0	143	149	0	27	28
2025	10	22	4	30	0	27.7	-1.3	0.964	0.5	0.4	0	49.9	52	0	143	149	0	27	28
2025	10	22	4	40	0	27.5	-1.7	0.964	0.5	0.4	0	49.5	52.5	0	143	149	0	28	27
2025	10	22	4	50	0	27.2	-1.7	0.964	0.4	0.3	0	49.9	52.5	0	143	150	0	27	28
2025	10	22	5	0	0	27.8	-1.7	0.964	0.5	0.5	0	49.9	52.5	0	143	150	0	27	28
2025	10	22	5	10	0	26.4	-1.7	0.964	0.5	0.4	0	49.9	52.5	0	143	150	0	27	28
2025	10	22	5	20	0	28.2	-1.3	0.964	0.5	0.4	0	49.9	52	0	143	149	0	27	28
2025	10	22	5	30	0	28.2	-1.4	0.964	0.4	0.3	0	49.9	52	0	143	149	0	27	28
2025	10	22	5	40	0	27.5	-2.1	0.964	0.5	0.4	0	49.5	52.5	0	143	149	0	28	27
2025	10	22	5	50	0	27.7	-1.3	0.964	0.5	0.5	0	49.9	52.9	0	143	150	0	27	27
2025	10	22	6	0	0	27.7	-0.9	0.964	0.5	0.5	0	49.9	52.5	0	143	150	0	27	28
2025	10	22	6	10	0	27.7	-1.6	0.964	0.5	0.4	0	49.5	52	0	143	149	0	28	28
2025	10	22	6	20	0	27.6	-1.2	0.964	0.5	0.4	0	49.5	52.5	0	143	150	0	28	28
2025	10	22	6	30	0	27.2	-1.7	0.964	0.5	0.4	0	49.5	52.9	0	143	150	0	28	27
2025	10	22	6	40	0	27.8	-2.6	0.964	0.5	0.5	0	49.9	52.5	0	143	150	0	27	28
2025	10	22	6	50	0	27.2	-1.3	0.964	0.4	0.3	0	49.5	52.5	0	143	150	0	28	28
2025	10	22	7	0	0	27.1	-1.2	0.964	0.5	0.4	0	49.9	52.5	0	143	150	0	27	28
2025	10	22	7	10	0	26.7	-1.7	0.964	0.5	0.5	0	49.9	52.5	0	143	150	0	27	28
2025	10	22	7	20	0	27.9	-1.9	0.964	0.5	0.4	0	49.5	52.9	0	142	150	0	27	27
2025	10	22	7	30	0	26.6	-3	0.964	0.5	0.4	0	49.5	52.5	0	142	149	0	27	27
2025	10	22	7	40	0	27	-1	0.964	0.5	0.4	0	49	53.3	0	142	151	0	28	27
2025	10	22	7	50	0	27.3	-2.5	0.964	0.5	0.4	0	49	52.9	0	141	151	0	27	28
2025	10	22	8	0	0	27.4	-2.2	0.964	0.5	0.5	0	49	52.9	0	141	151	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	22	8	10	0	27.6	-1.3	0.964	0.4	0.3	0	48.2	52.5	0	140	150	0	28	28
2025	10	22	8	20	0	27	-1.7	0.964	0.5	0.4	0	48.6	52.5	0	141	150	0	28	28
2025	10	22	8	30	0	27.5	-1.2	0.964	0.5	0.5	0	48.6	52	0	140	149	0	27	28
2025	10	22	8	40	0	26.9	-1.9	0.964	0.5	0.5	0	48.6	52.9	0	141	151	0	28	28
2025	10	22	8	50	0	28	-1.7	0.964	0.5	0.4	0	48.2	52.5	0	140	150	0	28	28
2025	10	22	9	0	0	26.5	-1.5	0.964	0.5	0.5	0	48.6	53.3	0	141	151	0	28	27
2025	10	22	9	10	0	27.8	-1	0.964	0.4	0.3	0	48.6	52.5	0	140	150	0	27	28
2025	10	22	9	20	0	27.7	-1.1	0.964	0.5	0.4	0	48.6	52	0	140	149	0	27	28
2025	10	22	9	30	0	26.9	-1.7	0.964	0.5	0.4	0	48.6	52	0	140	149	0	27	28
2025	10	22	9	40	0	27.6	-1	0.964	0.4	0.3	0	48.2	52	0	139	148	0	27	27
2025	10	22	9	50	0	27.2	-1.1	0.965	0.5	0.5	0	47.7	51.6	0	138	147	0	27	27
2025	10	22	10	0	0	27.6	-1.5	0.964	0.5	0.4	0	47.7	52	0	139	149	0	28	28
2025	10	22	10	10	0	26.8	-1.3	0.965	0.5	0.4	0	47.3	51.6	0	138	148	0	28	28
2025	10	22	10	20	0	26	-0.4	0.964	0.5	0.4	0	47.3	51.6	0	138	148	0	28	28
2025	10	22	10	30	0	27.4	-1.3	0.965	0.5	0.4	0	46.4	51.6	0	136	147	0	28	27
2025	10	22	10	40	0	27.4	-1.7	0.965	0.5	0.4	0	46.9	50.3	0	136	146	0	27	29
2025	10	22	10	50	0	27.8	-2	0.965	0.4	0.3	0	46.9	50.7	0	136	146	0	27	28
2025	10	22	11	0	0	26.2	-1	0.965	0.4	0.3	0	47.3	51.2	0	137	147	0	27	28
2025	10	22	11	10	0	26.9	-2	0.964	0.5	0.5	0	46.9	51.2	0	136	146	0	27	27
2025	10	22	11	20	0	27.6	-1.3	0.965	0.5	0.4	0	47.7	51.2	0	138	147	0	27	28
2025	10	22	11	30	0	26.3	-2.2	0.965	0.5	0.4	0	47.3	51.2	0	137	147	0	27	28
2025	10	22	11	40	0	26.1	-2.1	0.965	0.4	0.3	0	47.7	51.6	0	138	147	0	27	27
2025	10	22	11	50	0	28.3	-1.6	0.964	0.5	0.4	0	47.7	51.6	0	138	148	0	27	28
2025	10	22	12	0	0	27.2	-2	0.964	0.6	0.5	0	47.3	51.6	0	138	148	0	28	28
2025	10	22	12	10	0	26.9	-1.7	0.963	0.5	0.4	0	48.2	52	0	139	148	0	27	27
2025	10	22	12	20	0	27.1	-1.1	0.963	0.5	0.4	0	48.2	51.6	0	139	148	0	27	28
2025	10	22	12	30	0	27.2	-0.9	0.963	0.5	0.4	0	48.2	52	0	139	148	0	27	27
2025	10	22	12	40	0	27.7	-1.2	0.962	0.5	0.4	0	48.2	51.6	0	139	148	0	27	28
2025	10	22	12	50	0	27.5	-1.7	0.962	0.5	0.4	0	48.2	51.6	0	139	148	0	27	28
2025	10	22	13	0	0	26.7	-0.9	0.961	0.5	0.5	0	48.6	52.5	0	140	149	0	27	27
2025	10	22	13	10	0	25.8	-0.4	0.961	0.5	0.5	0	48.6	52	0	140	149	0	27	28
2025	10	22	13	20	0	27.2	-1.2	0.961	0.5	0.4	0	48.6	52	0	140	149	0	27	28
2025	10	22	13	30	0	27.7	-1.7	0.962	0.4	0.3	0	48.2	52.5	0	140	149	0	28	27
2025	10	22	13	40	0	26.3	-1.1	0.961	0.5	0.4	0	48.2	52.5	0	139	149	0	27	27
2025	10	22	13	50	0	27.2	-1.2	0.96	0.5	0.5	0	47.3	51.6	0	137	147	0	27	27
2025	10	22	14	0	0	27.5	-1.9	0.961	0.5	0.4	0	46.4	51.2	0	136	146	0	28	27
2025	10	22	14	10	0	26.9	-1.8	0.961	0.5	0.4	0	47.7	51.6	0	137	147	0	26	27
2025	10	22	14	20	0	26.2	-1.8	0.961	0.5	0.5	0	47.7	51.6	0	138	148	0	27	28
2025	10	22	14	30	0	28.3	-1.8	0.96	0.5	0.4	0	47.3	51.6	0	137	148	0	27	28
2025	10	22	14	40	0	26.5	-1.8	0.961	0.5	0.4	0	47.3	52	0	137	148	0	27	27
2025	10	22	14	50	0	27.7	-1.3	0.96	0.5	0.4	0	49	51.6	0	141	148	0	27	28
2025	10	22	15	0	0	26.9	-0.7	0.961	0.4	0.3	0	49.9	52.5	0	143	150	0	27	28
2025	10	22	15	10	0	26.2	-1.6	0.961	0.5	0.4	0	49.9	52.9	0	143	151	0	27	28
2025	10	22	15	20	0	26.8	-0.6	0.96	0.5	0.5	0	50.3	53.3	0	143	151	0	26	27
2025	10	22	15	30	0	26.7	-1.9	0.96	0.5	0.4	0	49.9	53.3	0	143	151	0	27	27
2025	10	22	15	40	0	25.6	-2.3	0.96	0.4	0.3	0	48.6	52.5	0	140	149	0	27	27
2025	10	22	15	50	0	27.6	-2	0.96	0.5	0.4	0	48.2	52	0	139	148	0	27	27
2025	10	22	16	0	0	27.2	-1.4	0.96	0.5	0.4	0	48.6	52.5	0	140	149	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	22	16	10	0	26.7	-1.1	0.96	0.5	0.4	0	48.6	52.5	0	140	149	0	27	27
2025	10	22	16	20	0	27.4	-1.8	0.96	0.5	0.4	0	48.6	52.5	0	140	149	0	27	27
2025	10	22	16	30	0	27.3	-1.7	0.96	0.5	0.4	0	48.2	52.5	0	139	149	0	27	27
2025	10	22	16	40	0	26.5	-2.1	0.96	0.5	0.4	0	48.6	52.5	0	140	149	0	27	27
2025	10	22	16	50	0	27	-1.9	0.96	0.3	0.2	0	48.2	52.5	0	139	149	0	27	27
2025	10	22	17	0	0	26.9	-2.2	0.96	0.5	0.5	0	48.2	51.6	0	139	148	0	27	28
2025	10	22	17	10	0	27.7	-1.4	0.96	0.5	0.4	0	47.7	52	0	139	148	0	28	27
2025	10	22	17	20	0	26.6	-2.2	0.96	0.5	0.4	0	48.2	52.5	0	139	149	0	27	27
2025	10	22	17	30	0	26.4	-1.4	0.96	0.5	0.4	0	48.2	52	0	139	148	0	27	27
2025	10	22	17	40	0	26.7	-1.8	0.959	0.5	0.4	0	48.6	52	0	140	149	0	27	28
2025	10	22	17	50	0	27	-1.6	0.96	0.5	0.4	0	47.7	51.6	0	138	148	0	27	28
2025	10	22	18	0	0	27.3	-1.3	0.96	0.5	0.5	0	48.2	52.5	0	139	149	0	27	27
2025	10	22	18	10	0	26.9	-1.7	0.959	0.5	0.4	0	48.2	51.6	0	139	148	0	27	28
2025	10	22	18	20	0	26.3	-0.8	0.961	0.5	0.4	0	48.2	52.5	0	140	150	0	28	28
2025	10	22	18	30	0	26.8	-2.3	0.96	0.5	0.5	0	48.6	52.9	0	140	150	0	27	27
2025	10	22	18	40	0	27.3	-1.6	0.959	0.4	0.3	0	48.6	52.9	0	140	150	0	27	27
2025	10	22	18	50	0	27.1	-2.3	0.959	0.5	0.4	0	48.2	52.9	0	139	150	0	27	27
2025	10	22	19	0	0	26.9	-0.7	0.959	0.5	0.5	0	48.6	52.5	0	140	149	0	27	27
2025	10	22	19	10	0	27.7	-1.9	0.959	0.4	0.3	0	48.2	52	0	139	149	0	27	28
2025	10	22	19	20	0	27.5	-1.3	0.959	0.5	0.4	0	48.2	52.5	0	140	150	0	28	28
2025	10	22	19	30	0	26.2	-1.1	0.959	0.5	0.4	0	48.6	52.9	0	140	150	0	27	27
2025	10	22	19	40	0	26.8	-1.8	0.959	0.5	0.4	0	48.6	52.5	0	140	150	0	27	28
2025	10	22	19	50	0	27.3	-1.9	0.959	0.5	0.4	0	48.6	53.3	0	140	150	0	27	26
2025	10	22	20	0	0	26.3	-1.7	0.959	0.5	0.4	0	48.2	52.9	0	139	150	0	27	27
2025	10	22	20	10	0	27	-2.2	0.959	0.4	0.3	0	48.2	52.9	0	139	150	0	27	27
2025	10	22	20	20	0	27.1	-1.5	0.959	0.5	0.4	0	48.2	53.3	0	140	151	0	28	27
2025	10	22	20	30	0	27.9	-1.3	0.959	0.5	0.4	0	48.6	53.3	0	140	151	0	27	27
2025	10	22	20	40	0	26.9	-1.5	0.958	0.5	0.4	0	48.2	52.9	0	140	151	0	28	28
2025	10	22	20	50	0	27.5	-1.1	0.958	0.6	0.5	0	51.2	52.9	0	146	151	0	27	28
2025	10	22	21	0	0	26.2	-2.6	0.958	0.5	0.5	0	51.2	53.3	0	146	151	0	27	27
2025	10	22	21	10	0	25.2	-0.8	0.958	0.5	0.4	0	51.6	53.8	0	147	152	0	27	27
2025	10	22	21	20	0	27.7	-2.2	0.958	0.4	0.3	0	51.2	52.9	0	146	151	0	27	28
2025	10	22	21	30	0	26.8	-1.1	0.958	0.5	0.4	0	51.6	53.8	0	146	152	0	26	27
2025	10	22	21	40	0	26.2	-1.8	0.958	0.4	0.3	0	51.2	53.3	0	146	152	0	27	28
2025	10	22	21	50	0	28	-2.8	0.958	0.4	0.3	0	51.2	53.3	0	146	152	0	27	28
2025	10	22	22	0	0	26.6	-0.8	0.957	0.5	0.4	0	51.2	53.8	0	146	152	0	27	27
2025	10	22	22	10	0	27.5	-1	0.957	0.4	0.3	0	50.7	53.3	0	145	151	0	27	27
2025	10	22	22	20	0	26.5	-1.1	0.957	0.5	0.4	0	51.6	53.8	0	147	152	0	27	27
2025	10	22	22	30	0	26.5	-3.5	0.958	0.5	0.5	0	51.2	53.3	0	146	151	0	27	27
2025	10	22	22	40	0	26.9	-1.2	0.957	0.5	0.5	0	50.3	52.9	0	144	151	0	27	28
2025	10	22	22	50	0	26.2	-0.8	0.957	0.5	0.4	0	50.7	53.8	0	145	152	0	27	27
2025	10	22	23	0	0	27.7	-1.7	0.957	0.6	0.5	0	50.3	53.8	0	144	152	0	27	27
2025	10	22	23	10	0	27.4	-1.8	0.957	0.4	0.3	0	50.3	53.8	0	144	152	0	27	27
2025	10	22	23	20	0	26.7	-1	0.957	0.4	0.3	0	50.7	53.3	0	145	152	0	27	28
2025	10	22	23	30	0	26.1	-1	0.957	0.5	0.4	0	50.3	53.3	0	144	152	0	27	28
2025	10	22	23	40	0	27.8	-2	0.957	0.5	0.5	0	50.3	53.3	0	144	151	0	27	27
2025	10	22	23	50	0	27.7	-2.2	0.957	0.5	0.4	0	50.3	53.8	0	144	152	0	27	27
2025	10	23	0	0	0	26.8	-1.4	0.957	0.6	0.5	0	50.7	53.3	0	145	152	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	23	0	10	0	27.4	-1.7	0.957	0.5	0.5	0	50.7	53.8	0	145	152	0	27	27
2025	10	23	0	20	0	26.2	-0.9	0.957	0.5	0.5	0	50.3	53.8	0	144	152	0	27	27
2025	10	23	0	30	0	26.6	-2.2	0.957	0.5	0.5	0	49.9	53.3	0	144	152	0	28	28
2025	10	23	0	40	0	26.6	-2.2	0.957	0.5	0.4	0	50.3	53.8	0	145	152	0	28	27
2025	10	23	0	50	0	26.6	-1.7	0.957	0.5	0.5	0	50.7	54.6	0	145	154	0	27	27
2025	10	23	1	0	0	27.2	-1	0.957	0.5	0.4	0	50.7	53.8	0	145	153	0	27	28
2025	10	23	1	10	0	26.8	-1.4	0.957	0.5	0.5	0	50.3	54.2	0	145	153	0	28	27
2025	10	23	1	20	0	27	-1.3	0.957	0.4	0.3	0	50.7	54.2	0	145	153	0	27	27
2025	10	23	1	30	0	26.3	-2.2	0.957	0.5	0.4	0	50.7	54.2	0	145	153	0	27	27
2025	10	23	1	40	0	27.4	-2.2	0.957	0.6	0.5	0	50.3	53.8	0	144	152	0	27	27
2025	10	23	1	50	0	26.2	-2.6	0.957	0.4	0.3	0	50.7	54.2	0	145	154	0	27	28
2025	10	23	2	0	0	27.6	-2.2	0.957	0.4	0.3	0	50.7	53.8	0	145	153	0	27	28
2025	10	23	2	10	0	26.6	-1.4	0.957	0.5	0.4	0	50.7	54.2	0	145	153	0	27	27
2025	10	23	2	20	0	27.2	-1.7	0.957	0.4	0.3	0	50.3	54.2	0	144	153	0	27	27
2025	10	23	2	30	0	27.8	-2.2	0.957	0.5	0.5	0	49.9	53.8	0	143	152	0	27	27
2025	10	23	2	40	0	27.3	-1.4	0.957	0.5	0.5	0	49.9	54.2	0	143	153	0	27	27
2025	10	23	2	50	0	26.8	-1.4	0.957	0.5	0.5	0	49.9	54.2	0	143	153	0	27	27
2025	10	23	3	0	0	26.6	-1.6	0.957	0.4	0.3	0	49.9	54.2	0	143	153	0	27	27
2025	10	23	3	10	0	26	-1.4	0.957	0.4	0.3	0	50.3	54.2	0	144	153	0	27	27
2025	10	23	3	20	0	26.9	-1.3	0.957	0.5	0.4	0	49.9	53.8	0	143	153	0	27	28
2025	10	23	3	30	0	27.4	-1.8	0.957	0.5	0.5	0	49.5	53.8	0	143	153	0	28	28
2025	10	23	3	40	0	27.8	-0.9	0.957	0.5	0.4	0	49.9	53.8	0	143	153	0	27	28
2025	10	23	3	50	0	27.3	-1.3	0.957	0.3	0.2	0	49.5	53.3	0	142	152	0	27	28
2025	10	23	4	0	0	27.7	-1.7	0.957	0.5	0.4	0	49.5	54.2	0	142	153	0	27	27
2025	10	23	4	10	0	27.3	-1.7	0.956	0.5	0.4	0	49.5	54.2	0	142	153	0	27	27
2025	10	23	4	20	0	26.5	-2.2	0.957	0.4	0.3	0	49.5	54.2	0	142	153	0	27	27
2025	10	23	4	30	0	26.8	-1.3	0.956	0.5	0.4	0	49	54.2	0	142	153	0	28	27
2025	10	23	4	40	0	25.5	-1.4	0.956	0.5	0.5	0	49	53.8	0	142	153	0	28	28
2025	10	23	4	50	0	27.7	-2.3	0.957	0.5	0.4	0	49.9	54.2	0	143	153	0	27	27
2025	10	23	5	0	0	25.6	-3.3	0.956	0.5	0.5	0	49.9	54.2	0	143	153	0	27	27
2025	10	23	5	10	0	26	-4.1	0.956	0.5	0.4	0	49.9	54.2	0	143	153	0	27	27
2025	10	23	5	20	0	25.9	-2	0.956	0.5	0.5	0	49.9	54.2	0	143	153	0	27	27
2025	10	23	5	30	0	25.8	-2.6	0.956	0.5	0.4	0	49.5	54.6	0	143	154	0	28	27
2025	10	23	5	40	0	25.7	-3.1	0.957	0.5	0.5	0	49.9	53.8	0	143	153	0	27	28
2025	10	23	5	50	0	25.8	-2.1	0.956	0.5	0.4	0	49.9	54.2	0	143	154	0	27	28
2025	10	23	6	0	0	26	-2.2	0.956	0.5	0.4	0	49.9	54.2	0	143	153	0	27	27
2025	10	23	6	10	0	25.7	-1.8	0.956	0.5	0.4	0	49.9	54.6	0	143	154	0	27	27
2025	10	23	6	20	0	26.9	-2.3	0.956	0.5	0.5	0	49.5	54.2	0	142	154	0	27	28
2025	10	23	6	30	0	26.8	-3.3	0.956	0.4	0.3	0	49.9	54.6	0	143	154	0	27	27
2025	10	23	6	40	0	26.4	-2	0.956	0.5	0.4	0	49.5	54.2	0	142	154	0	27	28
2025	10	23	6	50	0	26.1	-1.6	0.956	0.4	0.3	0	49.9	54.2	0	143	154	0	27	28
2025	10	23	7	0	0	26.3	-1.9	0.956	0.5	0.4	0	49	54.6	0	142	154	0	28	27
2025	10	23	7	10	0	27.8	-1.7	0.956	0.5	0.4	0	49.5	54.2	0	142	154	0	27	28
2025	10	23	7	20	0	25.6	-1.8	0.956	0.5	0.4	0	49	54.6	0	142	154	0	28	27
2025	10	23	7	30	0	27	-1.5	0.956	0.4	0.3	0	49.5	53.8	0	142	153	0	27	28
2025	10	23	7	40	0	25.4	-3	0.956	0.4	0.3	0	48.6	54.2	0	141	154	0	28	28
2025	10	23	7	50	0	27.3	-1.7	0.956	0.5	0.5	0	49	53.8	0	141	153	0	27	28
2025	10	23	8	0	0	26.4	-1.9	0.956	0.5	0.4	0	48.6	54.2	0	141	153	0	28	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	23	8	10	0	26.5	-2.2	0.956	0.5	0.4	0	49	54.6	0	141	154	0	27	27
2025	10	23	8	20	0	26	-1.9	0.956	0.5	0.5	0	49.9	55.5	0	143	155	0	27	26
2025	10	23	8	30	0	25.8	-1.7	0.956	0.5	0.5	0	49	53.8	0	141	153	0	27	28
2025	10	23	8	40	0	26.4	-1.7	0.956	0.5	0.4	0	49	54.2	0	141	154	0	27	28
2025	10	23	8	50	0	27.3	-1.4	0.956	0.4	0.3	0	51.6	54.2	0	147	153	0	27	27
2025	10	23	9	0	0	26.6	-1.9	0.956	0.5	0.5	0	51.6	54.2	0	147	154	0	27	28
2025	10	23	9	10	0	27	-1.8	0.956	0.5	0.4	0	51.2	53.8	0	146	153	0	27	28
2025	10	23	9	20	0	27.7	-2	0.956	0.5	0.4	0	49.9	53.3	0	144	151	0	28	27
2025	10	23	9	30	0	28.1	-2.4	0.956	0.5	0.4	0	50.3	53.8	0	144	152	0	27	27
2025	10	23	9	40	0	26.5	-1.6	0.956	0.5	0.4	0	51.2	53.8	0	146	153	0	27	28
2025	10	23	9	50	0	26.7	-2.3	0.956	0.4	0.3	0	50.7	53.3	0	145	152	0	27	28
2025	10	23	10	0	0	26.6	-0.9	0.956	0.4	0.3	0	50.3	53.3	0	144	151	0	27	27
2025	10	23	10	10	0	27.4	-1.7	0.956	0.4	0.3	0	49.5	53.3	0	143	151	0	28	27
2025	10	23	10	20	0	27.3	-2.6	0.956	0.5	0.4	0	50.3	53.3	0	144	152	0	27	28
2025	10	23	10	30	0	26.7	-1.3	0.956	0.4	0.3	0	50.7	53.8	0	145	152	0	27	27
2025	10	23	10	40	0	27.4	-1.8	0.956	0.5	0.4	0	49.9	53.3	0	143	151	0	27	27
2025	10	23	10	50	0	26.9	-2	0.957	0.4	0.3	0	49.9	52.9	0	143	151	0	27	28
2025	10	23	11	0	0	25.2	-1.7	0.957	0.5	0.4	0	50.7	53.8	0	144	152	0	26	27
2025	10	23	11	10	0	27.9	-1.5	0.957	0.5	0.4	0	49	52.5	0	142	150	0	28	28
2025	10	23	11	20	0	26.6	-2	0.957	0.4	0.3	0	49.9	53.3	0	143	151	0	27	27
2025	10	23	11	30	0	27.5	-1	0.957	0.5	0.4	0	49.5	52.5	0	142	150	0	27	28
2025	10	23	11	40	0	27	-2.6	0.957	0.5	0.4	0	49	52.9	0	142	150	0	28	27
2025	10	23	11	50	0	26.8	-1.6	0.957	0.5	0.4	0	49.5	52.9	0	142	151	0	27	28
2025	10	23	12	0	0	26.5	-1.6	0.957	0.4	0.3	0	49.5	52.9	0	143	151	0	28	28
2025	10	23	12	10	0	27.1	-2.5	0.957	0.5	0.4	0	49.5	52.5	0	142	150	0	27	28
2025	10	23	12	20	0	26.1	-2.2	0.957	0.4	0.3	0	49	52	0	141	149	0	27	28
2025	10	23	12	30	0	27.2	-2.3	0.957	0.5	0.5	0	49	52	0	141	149	0	27	28
2025	10	23	12	40	0	27.2	-1.2	0.957	0.4	0.3	0	49	52	0	141	149	0	27	28
2025	10	23	12	50	0	27	-1.6	0.957	0.4	0.3	0	48.6	52.5	0	140	149	0	27	27
2025	10	23	13	0	0	27.1	-1.3	0.957	0.5	0.5	0	51.2	52.5	0	146	150	0	27	28
2025	10	23	13	10	0	26.5	-1.3	0.957	0.5	0.4	0	50.7	52.5	0	145	150	0	27	28
2025	10	23	13	20	0	26.5	-2.4	0.957	0.5	0.4	0	49.5	51.6	0	142	148	0	27	28
2025	10	23	13	30	0	27.2	-2.1	0.957	0.5	0.5	0	49.9	52	0	143	149	0	27	28
2025	10	23	13	40	0	27.2	-1.1	0.957	0.4	0.3	0	49.9	52.5	0	143	149	0	27	27
2025	10	23	13	50	0	27.3	-2.2	0.957	0.5	0.4	0	49.9	52.5	0	143	149	0	27	27
2025	10	23	14	0	0	26.5	-1.5	0.957	0.4	0.3	0	51.6	52.5	0	147	149	0	27	27
2025	10	23	14	10	0	26.3	-0.7	0.957	0.4	0.3	0	51.6	52	0	147	149	0	27	28
2025	10	23	14	20	0	28.2	-1.9	0.957	0.3	0.2	0	50.7	51.6	0	144	147	0	26	27
2025	10	23	14	30	0	26	-0.9	0.957	0.5	0.5	0	50.3	52	0	145	148	0	28	27
2025	10	23	14	40	0	27.1	-1.5	0.957	0.5	0.5	0	49.9	51.2	0	143	147	0	27	28
2025	10	23	14	50	0	27.7	-1.6	0.957	0.4	0.3	0	49.5	51.6	0	142	148	0	27	28
2025	10	23	15	0	0	26.9	-1.1	0.957	0.5	0.4	0	49.5	51.6	0	142	147	0	27	27
2025	10	23	15	10	0	25.5	-1.2	0.957	0.4	0.3	0	49.5	51.6	0	142	147	0	27	27
2025	10	23	15	20	0	27.8	-0.9	0.957	0.4	0.3	0	49.5	51.6	0	142	147	0	27	27
2025	10	23	15	30	0	26.9	-1.8	0.957	0.5	0.4	0	49.5	51.6	0	142	147	0	27	27
2025	10	23	15	40	0	27.2	-1.6	0.957	0.4	0.3	0	49.5	52	0	142	148	0	27	27
2025	10	23	15	50	0	27.3	-0.9	0.957	0.5	0.4	0	49.5	51.6	0	142	147	0	27	27
2025	10	23	16	0	0	27.8	-0.5	0.957	0.5	0.4	0	49.5	51.6	0	142	147	0	27	27

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	23	16	10	0	27.8	-1.2	0.957	0.4	0.3	0	49.5	51.6	0	142	147	0	27	27
2025	10	23	16	20	0	25.7	-1.2	0.957	0.5	0.4	0	49.5	51.6	0	142	148	0	27	28
2025	10	23	16	30	0	27.1	-0.9	0.957	0.5	0.5	0	49.9	51.6	0	143	148	0	27	28
2025	10	23	16	40	0	26.6	-1.1	0.957	0.4	0.3	0	49.5	52	0	142	148	0	27	27
2025	10	23	16	50	0	26.5	-1.3	0.957	0.5	0.4	0	50.3	52.5	0	143	149	0	26	27
2025	10	23	17	0	0	27	-1.8	0.957	0.4	0.3	0	49	52.5	0	142	149	0	28	27
2025	10	23	17	10	0	26.4	-0.6	0.957	0.5	0.5	0	51.6	52.5	0	147	149	0	27	27
2025	10	23	17	20	0	28.4	-1.4	0.957	0.5	0.4	0	51.2	52	0	146	148	0	27	27
2025	10	23	17	30	0	27	-1.2	0.957	0.5	0.4	0	50.7	51.6	0	144	147	0	26	27
2025	10	23	17	40	0	27	-0.6	0.957	0.4	0.3	0	50.7	52	0	145	148	0	27	27
2025	10	23	17	50	0	28.1	-1	0.957	0.5	0.4	0	50.3	51.6	0	144	147	0	27	27
2025	10	23	18	0	0	26.8	-1	0.956	0.5	0.4	0	51.2	51.6	0	145	148	0	26	28
2025	10	23	18	10	0	26.9	-1.9	0.957	0.5	0.5	0	50.3	52	0	144	148	0	27	27
2025	10	23	18	20	0	26.1	-1.2	0.956	0.4	0.3	0	49.9	52	0	143	148	0	27	27
2025	10	23	18	30	0	26.5	-1	0.956	0.3	0.2	0	49.9	51.6	0	143	147	0	27	27
2025	10	23	18	40	0	27.4	-2.1	0.956	0.4	0.3	0	49.9	51.6	0	143	147	0	27	27
2025	10	23	18	50	0	26.8	-1.7	0.956	0.5	0.5	0	49.9	52	0	143	148	0	27	27
2025	10	23	19	0	0	26.9	-2.4	0.956	0.5	0.4	0	49.9	52	0	143	148	0	27	27
2025	10	23	19	10	0	27	-2.9	0.956	0.5	0.4	0	50.3	52	0	143	148	0	26	27
2025	10	23	19	20	0	26.5	-0.9	0.956	0.5	0.5	0	49.9	52	0	143	148	0	27	27
2025	10	23	19	30	0	25.9	-1.1	0.956	0.5	0.5	0	49.5	52	0	143	149	0	28	28
2025	10	23	19	40	0	27.2	-2.6	0.956	0.5	0.4	0	50.7	52.5	0	145	149	0	27	27
2025	10	23	19	50	0	27.3	-1.8	0.955	0.5	0.5	0	49.9	52	0	144	148	0	28	27
2025	10	23	20	0	0	27.1	-0.4	0.955	0.5	0.5	0	50.7	52.5	0	145	149	0	27	27
2025	10	23	20	10	0	27.8	-1.8	0.956	0.5	0.4	0	50.3	52.5	0	144	149	0	27	27
2025	10	23	20	20	0	27.1	-2.2	0.955	0.5	0.5	0	52	52.5	0	147	150	0	26	28
2025	10	23	20	30	0	27	-2.1	0.955	0.4	0.3	0	50.3	52.5	0	145	149	0	28	27
2025	10	23	20	40	0	27.7	-1.3	0.955	0.4	0.3	0	50.7	52.9	0	145	150	0	27	27
2025	10	23	20	50	0	26.9	-1.5	0.955	0.5	0.5	0	50.7	52.5	0	145	149	0	27	27
2025	10	23	21	0	0	26.4	-0.7	0.955	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	23	21	10	0	27.3	-1.2	0.955	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	23	21	20	0	26.8	-0.8	0.955	0.6	0.5	0	51.6	52.9	0	147	150	0	27	27
2025	10	23	21	30	0	26.9	-0.7	0.954	0.5	0.4	0	51.2	52.5	0	146	150	0	27	28
2025	10	23	21	40	0	26.7	-1.4	0.954	0.3	0.2	0	51.2	52.9	0	146	150	0	27	27
2025	10	23	21	50	0	26.8	-2	0.954	0.4	0.3	0	51.2	52.9	0	146	150	0	27	27
2025	10	23	22	0	0	27.4	-1.2	0.954	0.5	0.4	0	51.2	52.5	0	146	150	0	27	28
2025	10	23	22	10	0	27.3	-0.8	0.954	0.5	0.4	0	51.2	52.9	0	146	150	0	27	27
2025	10	23	22	20	0	26.4	-0.7	0.954	0.4	0.3	0	51.2	52.9	0	146	150	0	27	27
2025	10	23	22	30	0	26.8	-0.9	0.954	0.5	0.4	0	51.2	52.9	0	146	150	0	27	27
2025	10	23	22	40	0	26.7	-2.1	0.954	0.4	0.3	0	50.7	52.9	0	145	150	0	27	27
2025	10	23	22	50	0	26.4	-0.5	0.954	0.5	0.4	0	50.7	52.5	0	145	150	0	27	28
2025	10	23	23	0	0	27.5	-1.4	0.954	0.5	0.4	0	50.7	52.9	0	145	150	0	27	27
2025	10	23	23	10	0	26.7	-1.7	0.954	0.5	0.4	0	50.7	52.9	0	145	150	0	27	27
2025	10	23	23	20	0	26.6	-1.1	0.954	0.4	0.3	0	50.7	53.3	0	145	151	0	27	27
2025	10	23	23	30	0	27.7	-1.2	0.954	0.5	0.4	0	50.7	52.9	0	145	150	0	27	27
2025	10	23	23	40	0	26.6	-1.5	0.954	0.5	0.4	0	50.7	53.3	0	145	151	0	27	27
2025	10	23	23	50	0	26.6	-1.5	0.954	0.4	0.3	0	51.2	53.3	0	146	151	0	27	27
2025	10	24	0	0	0	26.3	-1.6	0.954	0.5	0.4	0	51.2	53.3	0	146	151	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	24	0	10	0	26.1	-2.3	0.954	0.5	0.5	0	50.7	53.3	0	145	151	0	27	27
2025	10	24	0	20	0	25.7	-1.4	0.954	0.5	0.4	0	50.7	53.3	0	145	151	0	27	27
2025	10	24	0	30	0	26.3	-0.6	0.954	0.5	0.4	0	50.7	53.3	0	145	151	0	27	27
2025	10	24	0	40	0	26.8	-1.7	0.954	0.5	0.4	0	50.7	52.9	0	145	151	0	27	28
2025	10	24	0	50	0	27.4	-2.1	0.954	0.3	0.2	0	50.7	52.9	0	145	151	0	27	28
2025	10	24	1	0	0	26.5	-2.2	0.954	0.5	0.4	0	50.7	53.3	0	145	151	0	27	27
2025	10	24	1	10	0	26.6	-2.4	0.954	0.5	0.5	0	50.3	52.9	0	145	151	0	28	28
2025	10	24	1	20	0	25.8	-2.6	0.954	0.4	0.3	0	50.3	53.3	0	144	151	0	27	27
2025	10	24	1	30	0	26.6	-2.4	0.953	0.5	0.5	0	50.7	53.3	0	145	151	0	27	27
2025	10	24	1	40	0	26	-2.5	0.953	0.4	0.3	0	50.3	52.9	0	144	151	0	27	28
2025	10	24	1	50	0	27.3	-1.8	0.954	0.4	0.3	0	49.9	53.3	0	144	151	0	28	27
2025	10	24	2	0	0	26.1	-1.3	0.953	0.5	0.4	0	50.3	53.3	0	144	151	0	27	27
2025	10	24	2	10	0	26.1	-2.2	0.953	0.5	0.4	0	50.7	53.3	0	144	151	0	26	27
2025	10	24	2	20	0	27.1	-1.6	0.953	0.5	0.4	0	49.5	52.5	0	143	150	0	28	28
2025	10	24	2	30	0	25.9	-1.1	0.953	0.5	0.4	0	52	52.9	0	148	151	0	27	28
2025	10	24	2	40	0	26.9	-1.3	0.953	0.5	0.5	0	51.6	52.9	0	147	151	0	27	28
2025	10	24	2	50	0	26.5	-1.5	0.953	0.4	0.3	0	52	52.9	0	148	151	0	27	28
2025	10	24	3	0	0	27.2	-0.7	0.953	0.5	0.4	0	51.6	53.3	0	147	151	0	27	27
2025	10	24	3	10	0	25.2	-1.3	0.953	0.5	0.4	0	51.6	53.3	0	147	151	0	27	27
2025	10	24	3	20	0	26.5	-1	0.953	0.6	0.5	0	51.6	52.9	0	147	150	0	27	27
2025	10	24	3	30	0	26.6	-1.3	0.953	0.4	0.3	0	52	52.9	0	148	151	0	27	28
2025	10	24	3	40	0	26.6	-1.4	0.953	0.4	0.3	0	51.2	52.5	0	147	150	0	28	28
2025	10	24	3	50	0	26.3	-1.8	0.953	0.5	0.4	0	51.6	52.9	0	147	151	0	27	28
2025	10	24	4	0	0	26.7	-1.8	0.953	0.5	0.4	0	51.6	53.3	0	147	151	0	27	27
2025	10	24	4	10	0	27.6	-1.6	0.953	0.5	0.4	0	51.6	52.5	0	147	150	0	27	28
2025	10	24	4	20	0	27.1	-2	0.953	0.4	0.3	0	51.2	52.5	0	147	150	0	28	28
2025	10	24	4	30	0	27.9	-2	0.953	0.5	0.5	0	51.2	52.5	0	146	150	0	27	28
2025	10	24	4	40	0	26.9	-1.4	0.953	0.5	0.4	0	51.6	52.9	0	147	150	0	27	27
2025	10	24	4	50	0	26.9	-1.4	0.953	0.5	0.4	0	51.2	52.9	0	147	151	0	28	28
2025	10	24	5	0	0	27.5	-2.2	0.953	0.5	0.4	0	51.6	52.5	0	147	150	0	27	28
2025	10	24	5	10	0	26.6	-0.9	0.953	0.5	0.4	0	51.6	53.3	0	147	151	0	27	27
2025	10	24	5	20	0	26.2	-1.9	0.953	0.6	0.5	0	51.6	52.9	0	147	150	0	27	27
2025	10	24	5	30	0	26.7	-2.4	0.953	0.5	0.4	0	51.2	52.9	0	146	150	0	27	27
2025	10	24	5	40	0	26.6	-2.1	0.953	0.5	0.4	0	51.2	52.5	0	147	150	0	28	28
2025	10	24	5	50	0	26.6	-1.7	0.953	0.5	0.5	0	51.2	52.9	0	146	150	0	27	27
2025	10	24	6	0	0	25.9	-0.8	0.953	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	24	6	10	0	26.8	-2.5	0.953	0.4	0.3	0	51.2	53.3	0	147	151	0	28	27
2025	10	24	6	20	0	26	-2.5	0.953	0.5	0.4	0	51.6	52.5	0	147	150	0	27	28
2025	10	24	6	30	0	26.2	-2.2	0.953	0.5	0.4	0	51.6	52.5	0	148	150	0	28	28
2025	10	24	6	40	0	27.1	-1.3	0.953	0.5	0.5	0	51.2	52.9	0	147	150	0	28	27
2025	10	24	6	50	0	27.3	-1.7	0.953	0.4	0.3	0	51.2	52.5	0	147	150	0	28	28
2025	10	24	7	0	0	26.6	-1.8	0.953	0.4	0.3	0	51.2	52.5	0	147	150	0	28	28
2025	10	24	7	10	0	27	-1.4	0.953	0.5	0.5	0	51.2	52.5	0	147	150	0	28	28
2025	10	24	7	20	0	26.4	-1.7	0.953	0.5	0.4	0	51.2	52.5	0	147	150	0	28	28
2025	10	24	7	30	0	26.8	-2.1	0.953	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	24	7	40	0	26.7	-1.4	0.953	0.5	0.5	0	50.7	52	0	145	149	0	27	28
2025	10	24	7	50	0	26.2	-3.2	0.953	0.5	0.4	0	51.6	52.5	0	146	149	0	26	27
2025	10	24	8	0	0	26.5	-2.2	0.953	0.5	0.4	0	50.7	51.6	0	145	148	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	24	8	10	0	26.4	-2.1	0.952	0.5	0.5	0	50.3	51.6	0	145	148	0	28	28
2025	10	24	8	20	0	27.6	-2.8	0.953	0.5	0.4	0	50.3	52	0	145	148	0	28	27
2025	10	24	8	30	0	27	-1.7	0.953	0.4	0.3	0	50.3	51.2	0	144	147	0	27	28
2025	10	24	8	40	0	26.4	-1	0.952	0.5	0.4	0	50.3	51.6	0	144	147	0	27	27
2025	10	24	8	50	0	26.7	-1.6	0.953	0.5	0.4	0	49.9	50.7	0	143	146	0	27	28
2025	10	24	9	0	0	26.8	-1.4	0.952	0.5	0.4	0	49.5	50.3	0	142	145	0	27	28
2025	10	24	9	10	0	26.7	-1.3	0.953	0.5	0.4	0	49	50.7	0	142	145	0	28	27
2025	10	24	9	20	0	26.9	-2.1	0.953	0.5	0.5	0	49.5	50.7	0	142	145	0	27	27
2025	10	24	9	30	0	27.2	-2.1	0.953	0.5	0.4	0	48.6	49.9	0	141	144	0	28	28
2025	10	24	9	40	0	27	-2.1	0.953	0.5	0.4	0	48.2	49.9	0	140	144	0	28	28
2025	10	24	9	50	0	26.9	-2.2	0.953	0.5	0.4	0	48.2	49.5	0	139	143	0	27	28
2025	10	24	10	0	0	26.5	-2.3	0.953	0.5	0.4	0	48.2	49.9	0	140	143	0	28	27
2025	10	24	10	10	0	25.2	-1.8	0.953	0.3	0.2	0	49	49.9	0	141	144	0	27	28
2025	10	24	10	20	0	26.1	-1.8	0.953	0.5	0.5	0	48.6	49.9	0	141	144	0	28	28
2025	10	24	10	30	0	27	-1.9	0.953	0.5	0.4	0	48.6	49.5	0	140	143	0	27	28
2025	10	24	10	40	0	27	-2.5	0.953	0.5	0.4	0	47.7	49.5	0	138	142	0	27	27
2025	10	24	10	50	0	27.4	-1.1	0.953	0.4	0.3	0	48.2	49	0	139	142	0	27	28
2025	10	24	11	0	0	26	-0.5	0.953	0.5	0.5	0	47.3	49	0	138	142	0	28	28
2025	10	24	11	10	0	27.2	-1.1	0.953	0.5	0.4	0	47.7	48.6	0	138	141	0	27	28
2025	10	24	11	20	0	27	-2.3	0.953	0.4	0.3	0	47.3	48.6	0	138	141	0	28	28
2025	10	24	11	30	0	27.1	-1.8	0.953	0.5	0.4	0	47.3	48.6	0	138	141	0	28	28
2025	10	24	11	40	0	26.6	-2.7	0.953	0.3	0.2	0	47.3	48.2	0	137	140	0	27	28
2025	10	24	11	50	0	27.1	-1.7	0.953	0.4	0.3	0	46.9	47.7	0	136	139	0	27	28
2025	10	24	12	0	0	27.9	-1.7	0.954	0.4	0.3	0	46.4	48.2	0	136	140	0	28	28
2025	10	24	12	10	0	26.7	-0.7	0.954	0.4	0.3	0	46.4	47.7	0	136	139	0	28	28
2025	10	24	12	20	0	26.4	-1.9	0.954	0.5	0.5	0	46.9	47.7	0	136	139	0	27	28
2025	10	24	12	30	0	28.1	-1.7	0.954	0.5	0.4	0	46.4	47.7	0	135	138	0	27	27
2025	10	24	12	40	0	27.6	-2.1	0.954	0.5	0.4	0	46.4	47.3	0	135	138	0	27	28
2025	10	24	12	50	0	26.8	-1.7	0.954	0.5	0.4	0	46.4	47.7	0	135	139	0	27	28
2025	10	24	13	0	0	26.5	-1.2	0.954	0.4	0.3	0	46.4	48.2	0	135	139	0	27	27
2025	10	24	13	10	0	26.9	-1.7	0.954	0.5	0.4	0	46.4	47.3	0	135	138	0	27	28
2025	10	24	13	20	0	26.9	-1.2	0.954	0.4	0.3	0	46	47.3	0	135	138	0	28	28
2025	10	24	13	30	0	27	-2.6	0.954	0.5	0.5	0	46	47.3	0	135	138	0	28	28
2025	10	24	13	40	0	26.7	-1.5	0.954	0.4	0.3	0	46.4	48.2	0	135	139	0	27	27
2025	10	24	13	50	0	27.4	-1.7	0.954	0.5	0.4	0	47.7	48.6	0	137	141	0	26	28
2025	10	24	14	0	0	27	-1.6	0.954	0.4	0.3	0	46.9	47.7	0	136	139	0	27	28
2025	10	24	14	10	0	25.5	-0.9	0.954	0.4	0.3	0	46.4	48.2	0	136	140	0	28	28
2025	10	24	14	20	0	26.2	-2	0.954	0.5	0.5	0	46.9	47.7	0	136	139	0	27	28
2025	10	24	14	30	0	26.9	-2.8	0.953	0.5	0.4	0	46.9	47.7	0	136	139	0	27	28
2025	10	24	14	40	0	27	-1	0.952	0.5	0.4	0	47.3	48.2	0	137	140	0	27	28
2025	10	24	14	50	0	28.2	-1.3	0.952	0.5	0.4	0	46.9	48.2	0	136	139	0	27	27
2025	10	24	15	0	0	27.1	-1.1	0.952	0.4	0.3	0	46.9	48.6	0	136	140	0	27	27
2025	10	24	15	10	0	27.3	-2.4	0.952	0.4	0.3	0	46.4	48.2	0	136	139	0	28	27
2025	10	24	15	20	0	26.7	-2	0.952	0.4	0.3	0	46.9	48.2	0	136	139	0	27	27
2025	10	24	15	30	0	27.2	-2.5	0.951	0.4	0.3	0	46.9	48.6	0	137	140	0	28	27
2025	10	24	15	40	0	25.6	-0.7	0.951	0.5	0.4	0	47.3	49	0	137	141	0	27	27
2025	10	24	15	50	0	26.7	-3.5	0.951	0.5	0.4	0	47.3	48.6	0	137	140	0	27	27
2025	10	24	16	0	0	27.8	-2.6	0.951	0.5	0.4	0	47.3	48.6	0	137	140	0	27	27

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	24	16	10	0	27.2	-1.8	0.95	0.5	0.4	0	47.7	49	0	138	141	0	27	27
2025	10	24	16	20	0	27.1	-2.3	0.95	0.4	0.3	0	47.7	48.6	0	138	141	0	27	28
2025	10	24	16	30	0	26.8	-1.8	0.95	0.5	0.4	0	48.2	49	0	139	142	0	27	28
2025	10	24	16	40	0	27.6	-2.5	0.95	0.5	0.5	0	48.2	49	0	139	142	0	27	28
2025	10	24	16	50	0	27.4	-1.7	0.95	0.5	0.4	0	47.7	49.5	0	138	142	0	27	27
2025	10	24	17	0	0	26.8	-1.2	0.95	0.5	0.5	0	48.2	49.5	0	139	142	0	27	27
2025	10	24	17	10	0	27.6	-2.8	0.95	0.5	0.4	0	47.7	48.6	0	138	141	0	27	28
2025	10	24	17	20	0	26.9	-2.3	0.95	0.5	0.4	0	47.7	48.6	0	137	141	0	26	28
2025	10	24	17	30	0	27.2	-1.9	0.95	0.5	0.4	0	48.2	49	0	138	141	0	26	27
2025	10	24	17	40	0	26.2	-1.6	0.95	0.4	0.3	0	48.6	49.5	0	139	142	0	26	27
2025	10	24	17	50	0	27.5	-1.4	0.95	0.5	0.5	0	47.7	49	0	138	142	0	27	28
2025	10	24	18	0	0	26.5	-2.1	0.95	0.5	0.5	0	47.7	49	0	138	142	0	27	28
2025	10	24	18	10	0	27	-1.8	0.95	0.5	0.5	0	47.7	48.6	0	138	141	0	27	28
2025	10	24	18	20	0	27.4	-1.8	0.95	0.5	0.5	0	48.2	49	0	139	142	0	27	28
2025	10	24	18	30	0	26.6	-1.7	0.95	0.4	0.3	0	48.2	49.5	0	139	142	0	27	27
2025	10	24	18	40	0	26.7	-2.7	0.95	0.6	0.5	0	48.2	49.5	0	139	142	0	27	27
2025	10	24	18	50	0	27.2	-2.1	0.95	0.4	0.3	0	48.6	50.3	0	140	144	0	27	27
2025	10	24	19	0	0	26.5	-1.3	0.95	0.5	0.5	0	49	50.3	0	141	144	0	27	27
2025	10	24	19	10	0	27	-1.9	0.95	0.3	0.2	0	49	50.3	0	141	144	0	27	27
2025	10	24	19	20	0	27.4	-1.7	0.95	0.5	0.5	0	49	49.9	0	141	144	0	27	28
2025	10	24	19	30	0	26.4	-0.9	0.95	0.4	0.3	0	49.5	50.7	0	142	145	0	27	27
2025	10	24	19	40	0	27.4	-2.8	0.949	0.5	0.5	0	49.5	50.7	0	142	145	0	27	27
2025	10	24	19	50	0	28	-2	0.949	0.4	0.3	0	49	50.3	0	141	145	0	27	28
2025	10	24	20	0	0	27.2	-1.8	0.949	0.5	0.4	0	49	51.2	0	142	146	0	28	27
2025	10	24	20	10	0	27.4	-1.5	0.949	0.5	0.4	0	49.5	50.7	0	142	146	0	27	28
2025	10	24	20	20	0	26.8	-1.6	0.949	0.5	0.5	0	49.5	51.2	0	142	146	0	27	27
2025	10	24	20	30	0	26.5	-1.4	0.949	0.5	0.4	0	49.5	50.7	0	142	146	0	27	28
2025	10	24	20	40	0	27.4	-1.7	0.949	0.4	0.3	0	49.5	50.7	0	142	146	0	27	28
2025	10	24	20	50	0	26.6	-1.4	0.949	0.5	0.4	0	49.9	51.6	0	143	147	0	27	27
2025	10	24	21	0	0	27.5	-1.7	0.949	0.5	0.5	0	49.9	51.6	0	143	147	0	27	27
2025	10	24	21	10	0	26.9	-1.3	0.948	0.5	0.4	0	49.9	51.6	0	143	147	0	27	27
2025	10	24	21	20	0	26	-1.4	0.948	0.5	0.4	0	50.3	51.6	0	144	147	0	27	27
2025	10	24	21	30	0	27.3	-1.9	0.948	0.5	0.5	0	49.9	51.2	0	143	147	0	27	28
2025	10	24	21	40	0	26.4	-0.9	0.948	0.4	0.3	0	49.9	51.6	0	144	148	0	28	28
2025	10	24	21	50	0	26.4	-1.3	0.948	0.5	0.4	0	50.3	52	0	144	148	0	27	27
2025	10	24	22	0	0	26.5	-1.9	0.948	0.5	0.4	0	50.3	52	0	144	148	0	27	27
2025	10	24	22	10	0	27	-1	0.948	0.6	0.5	0	49.9	51.6	0	144	148	0	28	28
2025	10	24	22	20	0	25.2	-0.6	0.948	0.5	0.4	0	50.3	51.6	0	144	148	0	27	28
2025	10	24	22	30	0	27.2	-2.2	0.948	0.5	0.4	0	50.3	51.6	0	144	148	0	27	28
2025	10	24	22	40	0	27.3	-1.1	0.948	0.4	0.3	0	50.7	52	0	145	149	0	27	28
2025	10	24	22	50	0	25.6	-1.6	0.948	0.5	0.4	0	50.7	52.5	0	145	149	0	27	27
2025	10	24	23	0	0	27	-1.3	0.948	0.4	0.3	0	50.7	52	0	145	149	0	27	28
2025	10	24	23	10	0	26.3	-0.6	0.948	0.4	0.3	0	50.7	52.5	0	145	149	0	27	27
2025	10	24	23	20	0	26.3	-0.9	0.948	0.3	0.2	0	50.7	52.5	0	145	149	0	27	27
2025	10	24	23	30	0	27.9	-1.7	0.948	0.5	0.4	0	50.7	52	0	145	149	0	27	28
2025	10	24	23	40	0	26.6	-2.4	0.948	0.4	0.3	0	50.7	52.9	0	145	150	0	27	27
2025	10	24	23	50	0	27.3	-2.4	0.948	0.4	0.3	0	50.7	52.5	0	145	149	0	27	27
2025	10	25	0	0	0	26.8	-1.2	0.948	0.5	0.4	0	50.7	52.5	0	145	149	0	27	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	25	0	10	0	26	-1.7	0.948	0.5	0.4	0	50.3	52	0	145	149	0	28	28
2025	10	25	0	20	0	27	-1.8	0.948	0.5	0.4	0	50.3	52	0	144	148	0	27	27
2025	10	25	0	30	0	26.9	-2.1	0.948	0.4	0.3	0	50.7	52	0	145	149	0	27	28
2025	10	25	0	40	0	27.3	-1.5	0.949	0.5	0.4	0	50.3	52.5	0	145	149	0	28	27
2025	10	25	0	50	0	26.3	-1.7	0.949	0.5	0.5	0	50.7	52	0	145	149	0	27	28
2025	10	25	1	0	0	27.3	-1.2	0.949	0.4	0.3	0	50.3	52	0	145	149	0	28	28
2025	10	25	1	10	0	26.7	-1.7	0.949	0.5	0.4	0	50.3	52.5	0	145	150	0	28	28
2025	10	25	1	20	0	26.1	-1.9	0.949	0.4	0.3	0	50.7	52.5	0	145	149	0	27	27
2025	10	25	1	30	0	25.8	-1.9	0.95	0.5	0.4	0	50.7	52.5	0	145	149	0	27	27
2025	10	25	1	40	0	27.4	-2.4	0.95	0.3	0.2	0	50.3	52.5	0	145	149	0	28	27
2025	10	25	1	50	0	27.8	-1.8	0.95	0.5	0.4	0	50.7	52	0	145	149	0	27	28
2025	10	25	2	0	0	26.7	-1.5	0.95	0.4	0.3	0	50.3	52	0	145	149	0	28	28
2025	10	25	2	10	0	27.7	-1.4	0.95	0.4	0.3	0	50.7	52	0	145	149	0	27	28
2025	10	25	2	20	0	26.2	-1.7	0.95	0.4	0.3	0	50.3	52	0	144	149	0	27	28
2025	10	25	2	30	0	25.6	-2.2	0.95	0.5	0.4	0	50.7	52.5	0	145	150	0	27	28
2025	10	25	2	40	0	28.2	-2.7	0.95	0.5	0.4	0	50.3	52	0	145	149	0	28	28
2025	10	25	2	50	0	26.9	-2.6	0.95	0.5	0.5	0	49.9	52.5	0	144	149	0	28	27
2025	10	25	3	0	0	26.9	-1.9	0.95	0.4	0.3	0	50.7	52	0	145	149	0	27	28
2025	10	25	3	10	0	26.6	-0.1	0.95	0.5	0.4	0	50.7	52.9	0	145	150	0	27	27
2025	10	25	3	20	0	25.8	-1.3	0.95	0.5	0.4	0	49.9	52	0	144	149	0	28	28
2025	10	25	3	30	0	26.6	-1.6	0.95	0.4	0.3	0	49.9	52	0	144	149	0	28	28
2025	10	25	3	40	0	27	-1.7	0.95	0.5	0.4	0	49.9	52.5	0	144	149	0	28	27
2025	10	25	3	50	0	26.6	-1.9	0.95	0.3	0.2	0	50.7	52	0	145	149	0	27	28
2025	10	25	4	0	0	26.1	-1.7	0.95	0.4	0.3	0	49.9	52	0	144	149	0	28	28
2025	10	25	4	10	0	26.6	-2.7	0.951	0.3	0.2	0	49.9	52	0	144	149	0	28	28
2025	10	25	4	20	0	26.9	-1.5	0.95	0.4	0.3	0	49.9	52	0	144	149	0	28	28
2025	10	25	4	30	0	26.5	-1.3	0.951	0.5	0.4	0	51.2	52	0	146	149	0	27	28
2025	10	25	4	40	0	25.7	-1.3	0.95	0.5	0.4	0	51.6	52	0	148	149	0	28	28
2025	10	25	4	50	0	27.4	-2.1	0.95	0.5	0.5	0	51.2	52	0	147	149	0	28	28
2025	10	25	5	0	0	26.2	-1.3	0.95	0.5	0.4	0	51.2	52	0	147	149	0	28	28
2025	10	25	5	10	0	26.6	-2.5	0.951	0.4	0.3	0	51.2	51.6	0	147	148	0	28	28
2025	10	25	5	20	0	27.1	-2.1	0.95	0.5	0.4	0	51.6	52	0	147	149	0	27	28
2025	10	25	5	30	0	27.4	-2.9	0.951	0.5	0.4	0	51.6	52.5	0	148	150	0	28	28
2025	10	25	5	40	0	26.9	-2.1	0.95	0.5	0.4	0	51.2	52.5	0	147	150	0	28	28
2025	10	25	5	50	0	27.5	-1.4	0.95	0.4	0.3	0	51.2	52.5	0	147	150	0	28	28
2025	10	25	6	0	0	28	-1.6	0.95	0.4	0.3	0	51.6	52	0	147	149	0	27	28
2025	10	25	6	10	0	26.9	-2.1	0.951	0.4	0.3	0	51.6	52.5	0	148	150	0	28	28
2025	10	25	6	20	0	26.2	-1.7	0.95	0.5	0.5	0	51.6	52.5	0	147	150	0	27	28
2025	10	25	6	30	0	26.7	-1.9	0.95	0.5	0.5	0	51.6	52.9	0	148	150	0	28	27
2025	10	25	6	40	0	27.6	-2.1	0.95	0.5	0.4	0	51.2	52.9	0	147	150	0	28	27
2025	10	25	6	50	0	26.8	-1.7	0.95	0.5	0.4	0	51.6	52.5	0	147	150	0	27	28
2025	10	25	7	0	0	27.2	-1.6	0.951	0.5	0.4	0	51.2	52.9	0	147	150	0	28	27
2025	10	25	7	10	0	26.1	-1.3	0.951	0.4	0.3	0	51.6	52	0	147	149	0	27	28
2025	10	25	7	20	0	26	-2	0.951	0.4	0.3	0	51.6	52	0	147	149	0	27	28
2025	10	25	7	30	0	26.9	-1.5	0.951	0.5	0.4	0	50.7	52	0	146	149	0	28	28
2025	10	25	7	40	0	27.1	-1	0.951	0.4	0.3	0	51.2	51.6	0	146	148	0	27	28
2025	10	25	7	50	0	26.5	-1.3	0.951	0.5	0.4	0	49.9	51.6	0	144	148	0	28	28
2025	10	25	8	0	0	26.8	-0.9	0.951	0.3	0.2	0	50.3	51.6	0	145	147	0	28	27

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	25	8	10	0	26.5	-1.7	0.951	0.5	0.4	0	49.9	51.6	0	144	147	0	28	27
2025	10	25	8	20	0	27.6	-1.7	0.951	0.5	0.5	0	50.3	51.6	0	144	147	0	27	27
2025	10	25	8	30	0	25	-1.2	0.951	0.5	0.5	0	49.5	50.7	0	143	146	0	28	28
2025	10	25	8	40	0	26.9	-0.8	0.95	0.5	0.4	0	49.9	51.2	0	143	146	0	27	27
2025	10	25	8	50	0	26.6	-1.7	0.951	0.5	0.4	0	49.5	50.3	0	142	145	0	27	28
2025	10	25	9	0	0	27.2	-0.8	0.951	0.5	0.4	0	49	50.3	0	141	145	0	27	28
2025	10	25	9	10	0	27.4	-3.3	0.951	0.5	0.4	0	48.6	49.9	0	141	144	0	28	28
2025	10	25	9	20	0	26	-0.6	0.951	0.5	0.5	0	48.2	49.9	0	140	143	0	28	27
2025	10	25	9	30	0	26.3	-1	0.951	0.5	0.4	0	48.6	49	0	140	142	0	27	28
2025	10	25	9	40	0	26.7	-1.9	0.951	0.4	0.3	0	48.2	49	0	139	142	0	27	28
2025	10	25	9	50	0	26.6	-1.7	0.951	0.5	0.4	0	47.7	48.6	0	139	142	0	28	29
2025	10	25	10	0	0	26.7	-1.1	0.951	0.5	0.5	0	47.7	48.6	0	138	141	0	27	28
2025	10	25	10	10	0	26.8	-1.7	0.951	0.4	0.3	0	48.2	49	0	139	142	0	27	28
2025	10	25	10	20	0	26.7	-1.9	0.951	0.4	0.3	0	47.7	49	0	139	142	0	28	28
2025	10	25	10	30	0	26.2	-1.9	0.951	0.5	0.5	0	47.3	48.2	0	138	141	0	28	29
2025	10	25	10	40	0	26.1	-1.4	0.951	0.5	0.4	0	48.6	49.5	0	140	143	0	27	28
2025	10	25	10	50	0	26.8	-2	0.951	0.4	0.3	0	47.7	48.6	0	139	141	0	28	28
2025	10	25	11	0	0	26.7	-1.4	0.951	0.5	0.4	0	47.3	48.6	0	138	141	0	28	28
2025	10	25	11	10	0	26.8	-3	0.951	0.5	0.4	0	47.7	48.6	0	138	141	0	27	28
2025	10	25	11	20	0	26.7	-1.1	0.951	0.4	0.3	0	47.3	48.6	0	138	141	0	28	28
2025	10	25	11	30	0	27	-1.9	0.951	0.4	0.3	0	47.3	49	0	138	142	0	28	28
2025	10	25	11	40	0	26.4	-0.9	0.951	0.4	0.3	0	47.3	49	0	138	141	0	28	27
2025	10	25	11	50	0	27.6	-3	0.952	0.5	0.5	0	47.3	48.2	0	137	140	0	27	28
2025	10	25	12	0	0	26.8	-1.8	0.951	0.5	0.5	0	47.3	48.2	0	138	140	0	28	28
2025	10	25	12	10	0	27.8	-1.2	0.951	0.4	0.3	0	47.3	48.2	0	137	140	0	27	28
2025	10	25	12	20	0	28.1	-0.2	0.951	0.5	0.4	0	46.9	48.2	0	137	140	0	28	28
2025	10	25	12	30	0	26.9	-2.1	0.952	0.5	0.5	0	46.9	48.2	0	137	140	0	28	28
2025	10	25	12	40	0	26.8	-1.7	0.951	0.5	0.4	0	46.9	48.2	0	136	139	0	27	27
2025	10	25	12	50	0	27.2	-1.7	0.952	0.4	0.3	0	47.7	49	0	138	141	0	27	27
2025	10	25	13	0	0	27.2	-2.2	0.952	0.5	0.4	0	47.7	49.5	0	139	142	0	28	27
2025	10	25	13	10	0	26.4	-1.8	0.951	0.5	0.4	0	47.3	48.6	0	138	141	0	28	28
2025	10	25	13	20	0	25.5	-1.4	0.951	0.5	0.4	0	47.7	49	0	139	142	0	28	28
2025	10	25	13	30	0	26.6	-1.4	0.95	0.4	0.3	0	47.3	48.2	0	137	140	0	27	28
2025	10	25	13	40	0	27.6	-1.7	0.949	0.5	0.4	0	47.3	48.6	0	137	140	0	27	27
2025	10	25	13	50	0	26.9	-1.6	0.949	0.5	0.5	0	47.7	48.6	0	139	141	0	28	28
2025	10	25	14	0	0	28.2	-2.6	0.949	0.5	0.4	0	47.7	48.6	0	138	141	0	27	28
2025	10	25	14	10	0	27.3	-1.9	0.949	0.5	0.5	0	47.7	48.6	0	138	140	0	27	27
2025	10	25	14	20	0	27.2	-2	0.95	0.5	0.5	0	47.3	49	0	138	141	0	28	27
2025	10	25	14	30	0	26.9	-2.7	0.949	0.5	0.4	0	47.7	49	0	138	141	0	27	27
2025	10	25	14	40	0	26.5	-1.7	0.949	0.4	0.3	0	47.3	49	0	138	141	0	28	27
2025	10	25	14	50	0	26.1	-0.9	0.948	0.5	0.4	0	47.7	49	0	138	141	0	27	27
2025	10	25	15	0	0	27	-1.9	0.948	0.4	0.3	0	47.7	48.6	0	138	141	0	27	28
2025	10	25	15	10	0	28.4	-1.9	0.948	0.5	0.4	0	47.3	48.2	0	137	140	0	27	28
2025	10	25	15	20	0	26.8	-2.4	0.948	0.4	0.3	0	47.7	48.6	0	138	141	0	27	28
2025	10	25	15	30	0	27.5	-2.1	0.948	0.5	0.5	0	47.7	48.6	0	138	141	0	27	28
2025	10	25	15	40	0	26.8	-1.7	0.948	0.4	0.3	0	47.7	49.5	0	139	142	0	28	27
2025	10	25	15	50	0	27.1	-2	0.948	0.5	0.4	0	48.2	49.5	0	139	142	0	27	27
2025	10	25	16	0	0	27	-1.5	0.948	0.5	0.4	0	48.2	49	0	139	142	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	25	16	10	0	26.3	-1.3	0.948	0.5	0.4	0	47.7	49	0	138	141	0	27	27
2025	10	25	16	20	0	26.4	-1.8	0.948	0.6	0.5	0	47.3	48.6	0	138	141	0	28	28
2025	10	25	16	30	0	27.9	-2	0.948	0.5	0.4	0	47.7	49.5	0	139	142	0	28	27
2025	10	25	16	40	0	27.2	-1.7	0.948	0.5	0.5	0	48.2	49	0	139	142	0	27	28
2025	10	25	16	50	0	27.1	-2.4	0.948	0.5	0.5	0	48.2	49	0	139	142	0	27	28
2025	10	25	17	0	0	26.8	-1.6	0.948	0.5	0.4	0	48.2	49	0	139	142	0	27	28
2025	10	25	17	10	0	26.9	-1.8	0.948	0.4	0.3	0	47.7	49.5	0	139	142	0	28	27
2025	10	25	17	20	0	27.5	-1.4	0.948	0.4	0.3	0	48.2	49.5	0	139	142	0	27	27
2025	10	25	17	30	0	26.4	-1.3	0.948	0.4	0.3	0	48.2	49.9	0	140	143	0	28	27
2025	10	25	17	40	0	27.5	-1.8	0.948	0.5	0.4	0	49	49.9	0	141	144	0	27	28
2025	10	25	17	50	0	26.4	-2	0.948	0.4	0.3	0	49.5	50.7	0	142	145	0	27	27
2025	10	25	18	0	0	25.5	-1.4	0.947	0.5	0.4	0	49.5	50.7	0	142	145	0	27	27
2025	10	25	18	10	0	26.8	-1.9	0.948	0.5	0.4	0	49	50.7	0	141	145	0	27	27
2025	10	25	18	20	0	27.1	-1	0.948	0.4	0.3	0	49.9	51.2	0	143	146	0	27	27
2025	10	25	18	30	0	25.7	-2.6	0.948	0.6	0.5	0	49	50.7	0	141	146	0	27	28
2025	10	25	18	40	0	27	-1.9	0.948	0.6	0.5	0	50.3	50.7	0	144	145	0	27	27
2025	10	25	18	50	0	26.8	-2.2	0.948	0.5	0.4	0	50.3	51.2	0	144	146	0	27	27
2025	10	25	19	0	0	26.7	-1.6	0.948	0.5	0.5	0	51.2	51.6	0	146	148	0	27	28
2025	10	25	19	10	0	26.2	-1.9	0.948	0.5	0.5	0	50.7	51.6	0	145	147	0	27	27
2025	10	25	19	20	0	26.3	-1.8	0.947	0.4	0.3	0	50.7	51.6	0	145	147	0	27	27
2025	10	25	19	30	0	26	-2.4	0.947	0.4	0.3	0	50.7	51.6	0	145	147	0	27	27
2025	10	25	19	40	0	26.9	-2.2	0.947	0.5	0.5	0	50.3	51.6	0	145	147	0	28	27
2025	10	25	19	50	0	27.1	-0.7	0.947	0.5	0.4	0	50.7	52	0	145	148	0	27	27
2025	10	25	20	0	0	26.9	-2	0.947	0.5	0.4	0	51.2	52	0	146	148	0	27	27
2025	10	25	20	10	0	27.7	-2.5	0.947	0.5	0.4	0	50.7	52	0	146	149	0	28	28
2025	10	25	20	20	0	27	-1.7	0.947	0.5	0.4	0	51.2	52.5	0	146	149	0	27	27
2025	10	25	20	30	0	27.3	-1.9	0.947	0.5	0.5	0	51.2	52	0	146	149	0	27	28
2025	10	25	20	40	0	27.8	-1.6	0.947	0.5	0.4	0	51.2	52.5	0	146	149	0	27	27
2025	10	25	20	50	0	27.1	-1.6	0.947	0.5	0.4	0	51.6	52	0	147	149	0	27	28
2025	10	25	21	0	0	26.6	-1.2	0.947	0.5	0.4	0	51.2	52	0	146	149	0	27	28
2025	10	25	21	10	0	26.5	-1	0.946	0.5	0.5	0	51.6	52.9	0	147	150	0	27	27
2025	10	25	21	20	0	26.1	-1.6	0.946	0.5	0.5	0	51.6	52.9	0	147	150	0	27	27
2025	10	25	21	30	0	26.9	-1.5	0.946	0.5	0.4	0	51.6	52.9	0	147	150	0	27	27
2025	10	25	21	40	0	27.2	-2.5	0.946	0.5	0.4	0	52	53.3	0	148	151	0	27	27
2025	10	25	21	50	0	27	-1.8	0.946	0.5	0.4	0	51.6	52.5	0	147	150	0	27	28
2025	10	25	22	0	0	26.7	-1.3	0.946	0.5	0.4	0	52	52.9	0	148	151	0	27	28
2025	10	25	22	10	0	26.7	-2.2	0.946	0.5	0.4	0	51.6	52.9	0	147	151	0	27	28
2025	10	25	22	20	0	26	-1.5	0.946	0.5	0.5	0	52	53.3	0	148	151	0	27	27
2025	10	25	22	30	0	24.2	-0.4	0.946	0.5	0.4	0	51.6	53.3	0	148	151	0	28	27
2025	10	25	22	40	0	26.7	-2.2	0.946	0.5	0.4	0	51.6	52.9	0	148	151	0	28	28
2025	10	25	22	50	0	27.4	-1.9	0.946	0.5	0.4	0	52	52.9	0	148	151	0	27	28
2025	10	25	23	0	0	25.8	-0.6	0.946	0.5	0.4	0	52.5	53.3	0	148	152	0	26	28
2025	10	25	23	10	0	27.3	-2.2	0.946	0.4	0.3	0	52.5	53.3	0	149	151	0	27	27
2025	10	25	23	20	0	26.3	-1.3	0.946	0.5	0.4	0	52	52.9	0	149	151	0	28	28
2025	10	25	23	30	0	26.5	-1.5	0.946	0.5	0.4	0	52.5	52.9	0	149	151	0	27	28
2025	10	25	23	40	0	26.8	-1.9	0.946	0.5	0.5	0	52.5	52.9	0	149	151	0	27	28
2025	10	25	23	50	0	26.3	-1.7	0.946	0.6	0.5	0	52.5	52.9	0	149	151	0	27	28
2025	10	26	0	0	0	26.5	-1.3	0.946	0.5	0.4	0	52.5	52.9	0	149	151	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	26	0	10	0	26.2	-1.2	0.946	0.4	0.3	0	52.5	53.3	0	150	151	0	28	27
2025	10	26	0	20	0	26.6	-1.7	0.946	0.5	0.5	0	52.5	53.3	0	149	151	0	27	27
2025	10	26	0	30	0	27.6	-0.9	0.946	0.4	0.3	0	52.9	52.5	0	150	150	0	27	28
2025	10	26	0	40	0	26.5	-1.5	0.946	0.5	0.5	0	52.9	52.9	0	150	150	0	27	27
2025	10	26	0	50	0	26.6	-1.9	0.946	0.5	0.5	0	53.3	52.5	0	151	151	0	27	29
2025	10	26	1	0	0	26.7	-2.6	0.946	0.5	0.4	0	52.5	52.9	0	150	150	0	28	27
2025	10	26	1	10	0	27.1	-2.3	0.946	0.4	0.3	0	52.9	52.9	0	150	151	0	27	28
2025	10	26	1	20	0	26.4	-1.3	0.946	0.5	0.5	0	52.9	52.5	0	150	151	0	27	29
2025	10	26	1	30	0	26.9	-0.3	0.945	0.5	0.5	0	53.3	53.3	0	151	151	0	27	27
2025	10	26	1	40	0	25.7	-1	0.946	0.5	0.4	0	52.9	52.9	0	150	151	0	27	28
2025	10	26	1	50	0	26.4	-2.4	0.946	0.4	0.3	0	52.5	52.9	0	150	151	0	28	28
2025	10	26	2	0	0	26.1	-1.8	0.946	0.5	0.5	0	52.9	53.3	0	150	151	0	27	27
2025	10	26	2	10	0	26.9	-1.3	0.946	0.5	0.4	0	52.5	52.9	0	149	151	0	27	28
2025	10	26	2	20	0	26.9	-1.9	0.946	0.5	0.4	0	52.9	52.9	0	150	151	0	27	28
2025	10	26	2	30	0	26.6	-2	0.946	0.5	0.4	0	52.9	52.9	0	150	151	0	27	28
2025	10	26	2	40	0	25.7	-1.2	0.946	0.5	0.5	0	52.5	52.9	0	150	151	0	28	28
2025	10	26	2	50	0	26.7	-0.6	0.946	0.5	0.5	0	52.5	52.9	0	150	151	0	28	28
2025	10	26	3	0	0	26.7	-1.1	0.947	0.4	0.3	0	52.5	52.9	0	150	151	0	28	28
2025	10	26	3	10	0	26.1	-2	0.947	0.5	0.4	0	52.9	53.3	0	150	151	0	27	27
2025	10	26	3	20	0	26.5	-2.1	0.948	0.5	0.4	0	52.5	52.5	0	150	150	0	28	28
2025	10	26	3	30	0	26.9	-2.2	0.948	0.5	0.4	0	52.5	52.5	0	150	150	0	28	28
2025	10	26	3	40	0	27.7	-1.7	0.948	0.5	0.4	0	52.5	53.3	0	150	151	0	28	27
2025	10	26	3	50	0	26.5	-2.1	0.949	0.6	0.5	0	52.5	52.5	0	149	150	0	27	28
2025	10	26	4	0	0	27.4	-2.1	0.948	0.5	0.4	0	52	52.5	0	149	150	0	28	28
2025	10	26	4	10	0	26.6	-1.5	0.949	0.5	0.5	0	52.5	52.9	0	149	151	0	27	28
2025	10	26	4	20	0	26.2	-2.2	0.949	0.5	0.5	0	52.5	52.5	0	150	150	0	28	28
2025	10	26	4	30	0	26.3	-2	0.949	0.4	0.3	0	52.9	52.9	0	150	150	0	27	27
2025	10	26	4	40	0	26.4	-1.6	0.949	0.5	0.4	0	52.9	52.9	0	150	151	0	27	28
2025	10	26	4	50	0	27.1	-2.1	0.949	0.4	0.3	0	52.9	53.3	0	150	151	0	27	27
2025	10	26	5	0	0	26.9	-1.9	0.95	0.4	0.3	0	52.5	52.5	0	150	150	0	28	28
2025	10	26	5	10	0	27.7	-2	0.949	0.4	0.3	0	52.5	52.5	0	149	150	0	27	28
2025	10	26	5	20	0	26	-1.9	0.95	0.6	0.5	0	52.5	52.9	0	150	151	0	28	28
2025	10	26	5	30	0	26.4	-2.1	0.949	0.4	0.3	0	52.9	52.9	0	150	151	0	27	28
2025	10	26	5	40	0	26.7	-1.7	0.949	0.4	0.3	0	52.5	52.5	0	149	150	0	27	28
2025	10	26	5	50	0	27.1	-2	0.95	0.4	0.3	0	52	52.9	0	149	150	0	28	27
2025	10	26	6	0	0	26.4	-1.3	0.95	0.5	0.4	0	52.5	52.9	0	150	151	0	28	28
2025	10	26	6	10	0	26.2	-1.9	0.95	0.5	0.5	0	52.5	53.3	0	150	151	0	28	27
2025	10	26	6	20	0	26.4	-2.2	0.95	0.5	0.4	0	52.9	53.3	0	150	151	0	27	27
2025	10	26	6	30	0	26	-2.1	0.95	0.5	0.5	0	52.5	52.9	0	150	151	0	28	28
2025	10	26	6	40	0	26.9	-1.7	0.95	0.4	0.3	0	52.5	52.9	0	150	151	0	28	28
2025	10	26	6	50	0	26.2	-2.2	0.95	0.5	0.4	0	52.5	52.5	0	149	150	0	27	28
2025	10	26	7	0	0	26.6	-0.5	0.95	0.5	0.4	0	52.5	52.9	0	150	151	0	28	28
2025	10	26	7	10	0	27	-2.1	0.95	0.5	0.5	0	52.5	52.9	0	150	151	0	28	28
2025	10	26	7	20	0	26.7	-1.6	0.95	0.5	0.5	0	52	52.5	0	149	150	0	28	28
2025	10	26	7	30	0	27.4	-1.3	0.95	0.5	0.4	0	51.6	52.5	0	148	150	0	28	28
2025	10	26	7	40	0	27	-1.7	0.95	0.4	0.3	0	52	52.5	0	148	149	0	27	27
2025	10	26	7	50	0	27.7	-2.7	0.95	0.4	0.3	0	51.6	52	0	147	149	0	27	28
2025	10	26	8	0	0	27.6	-1.9	0.95	0.5	0.4	0	51.6	52	0	147	149	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	26	8	10	0	25.8	-2	0.95	0.3	0.2	0	51.2	52	0	147	149	0	28	28
2025	10	26	8	20	0	27.5	-2.2	0.95	0.5	0.5	0	51.2	52	0	146	148	0	27	27
2025	10	26	8	30	0	26.7	-1.1	0.95	0.5	0.4	0	50.7	51.6	0	146	148	0	28	28
2025	10	26	8	40	0	26.4	-1.6	0.951	0.4	0.3	0	50.7	51.6	0	146	148	0	28	28
2025	10	26	8	50	0	26.8	-1.8	0.951	0.5	0.4	0	50.7	51.2	0	145	147	0	27	28
2025	10	26	9	0	0	26.8	-2.1	0.951	0.5	0.4	0	50.3	51.2	0	145	147	0	28	28
2025	10	26	9	10	0	27.5	-1.7	0.951	0.5	0.4	0	50.7	51.2	0	145	146	0	27	27
2025	10	26	9	20	0	27.1	-1.5	0.951	0.5	0.4	0	49.9	50.3	0	144	146	0	28	29
2025	10	26	9	30	0	27.3	-1.4	0.951	0.5	0.4	0	50.3	51.2	0	144	146	0	27	27
2025	10	26	9	40	0	27.7	-1.3	0.951	0.5	0.4	0	49.5	50.7	0	143	145	0	28	27
2025	10	26	9	50	0	26.6	-1.8	0.951	0.4	0.3	0	49.9	50.7	0	144	146	0	28	28
2025	10	26	10	0	0	26.2	-0.8	0.951	0.4	0.3	0	49.9	50.7	0	144	146	0	28	28
2025	10	26	10	10	0	26.6	-2.6	0.951	0.4	0.3	0	49.9	50.3	0	143	145	0	27	28
2025	10	26	10	20	0	27.2	-2.4	0.951	0.4	0.3	0	49	49.9	0	142	144	0	28	28
2025	10	26	10	30	0	25.6	-1.8	0.951	0.5	0.4	0	49.5	49.9	0	143	145	0	28	29
2025	10	26	10	40	0	28.1	-1.8	0.951	0.5	0.5	0	49	49.9	0	142	144	0	28	28
2025	10	26	10	50	0	27.3	-1.9	0.952	0.5	0.5	0	49	49.9	0	142	144	0	28	28
2025	10	26	11	0	0	28.6	-1.8	0.951	0.5	0.4	0	49.5	49.9	0	142	144	0	27	28
2025	10	26	11	10	0	27.2	-0.4	0.951	0.6	0.5	0	48.6	49.9	0	141	144	0	28	28
2025	10	26	11	20	0	27.4	-1.4	0.952	0.4	0.3	0	48.6	49.5	0	141	143	0	28	28
2025	10	26	11	30	0	26.5	-2.1	0.952	0.5	0.4	0	49	49.9	0	141	144	0	27	28
2025	10	26	11	40	0	25.9	-2.7	0.951	0.4	0.3	0	49.5	50.3	0	143	145	0	28	28
2025	10	26	11	50	0	26.3	-2.3	0.952	0.5	0.5	0	50.3	51.2	0	144	146	0	27	27
2025	10	26	12	0	0	26.7	-2.7	0.951	0.5	0.5	0	49.5	50.3	0	143	145	0	28	28
2025	10	26	12	10	0	26.6	-1.3	0.952	0.3	0.2	0	49.5	50.7	0	143	146	0	28	28
2025	10	26	12	20	0	27.5	-1.7	0.952	0.5	0.4	0	49.9	50.3	0	143	145	0	27	28
2025	10	26	12	30	0	26.8	-1.7	0.951	0.5	0.4	0	49.9	50.3	0	143	145	0	27	28
2025	10	26	12	40	0	25.9	-2.2	0.952	0.5	0.4	0	49.9	50.3	0	143	145	0	27	28
2025	10	26	12	50	0	27.7	-2.4	0.951	0.4	0.3	0	49.9	50.3	0	143	145	0	27	28
2025	10	26	13	0	0	27.5	-1.2	0.951	0.5	0.4	0	49.5	50.3	0	142	145	0	27	28
2025	10	26	13	10	0	27.2	-1.7	0.95	0.5	0.4	0	49.5	49.9	0	142	144	0	27	28
2025	10	26	13	20	0	27	-1.7	0.951	0.4	0.3	0	49	49.5	0	141	143	0	27	28
2025	10	26	13	30	0	26.1	-2.1	0.949	0.5	0.4	0	48.6	49.9	0	141	143	0	28	27
2025	10	26	13	40	0	27.7	-1.4	0.951	0.5	0.4	0	50.3	50.7	0	144	146	0	27	28
2025	10	26	13	50	0	28	-1.8	0.951	0.5	0.4	0	50.3	51.6	0	144	147	0	27	27
2025	10	26	14	0	0	26.7	-2.2	0.95	0.4	0.3	0	49.9	51.2	0	143	146	0	27	27
2025	10	26	14	10	0	27.2	-1.2	0.951	0.5	0.4	0	49.5	50.7	0	142	145	0	27	27
2025	10	26	14	20	0	27.3	-2.6	0.95	0.5	0.4	0	49.5	50.3	0	142	144	0	27	27
2025	10	26	14	30	0	27.1	-1.6	0.951	0.4	0.3	0	49.5	50.3	0	142	145	0	27	28
2025	10	26	14	40	0	26.9	-2.4	0.95	0.5	0.4	0	50.3	51.2	0	144	147	0	27	28
2025	10	26	14	50	0	27.2	-2.6	0.95	0.5	0.4	0	51.2	52	0	147	149	0	28	28
2025	10	26	15	0	0	26.3	-2.1	0.95	0.5	0.4	0	51.2	51.6	0	146	148	0	27	28
2025	10	26	15	10	0	25.8	-0.9	0.95	0.6	0.5	0	50.3	51.2	0	144	147	0	27	28
2025	10	26	15	20	0	27.4	-1.2	0.95	0.5	0.4	0	49.5	51.2	0	143	146	0	28	27
2025	10	26	15	30	0	27.4	-0.9	0.949	0.5	0.4	0	49.5	50.7	0	143	146	0	28	28
2025	10	26	15	40	0	26.9	-1.7	0.95	0.5	0.4	0	49.9	50.7	0	143	145	0	27	27
2025	10	26	15	50	0	27.6	-2.7	0.949	0.5	0.4	0	49.9	50.3	0	143	145	0	27	28
2025	10	26	16	0	0	26	-2.9	0.949	0.5	0.4	0	49.9	50.7	0	144	146	0	28	28

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	26	16	10	0	27.9	-1.1	0.948	0.5	0.4	0	49.9	50.3	0	143	145	0	27	28
2025	10	26	16	20	0	25.9	-0.9	0.949	0.4	0.3	0	49.5	50.3	0	143	145	0	28	28
2025	10	26	16	30	0	26.8	-2.1	0.948	0.5	0.4	0	49.5	50.7	0	143	145	0	28	27
2025	10	26	16	40	0	27.1	-2.2	0.948	0.5	0.4	0	49.9	50.7	0	143	146	0	27	28
2025	10	26	16	50	0	26	-2.1	0.948	0.5	0.5	0	49.9	51.2	0	143	146	0	27	27
2025	10	26	17	0	0	26.4	-2.3	0.948	0.4	0.3	0	50.3	51.2	0	144	146	0	27	27
2025	10	26	17	10	0	26.9	-1.2	0.948	0.5	0.4	0	49.5	51.2	0	143	146	0	28	27
2025	10	26	17	20	0	26.4	-1.8	0.948	0.5	0.4	0	49	50.7	0	142	145	0	28	27
2025	10	26	17	30	0	28	-1.7	0.948	0.5	0.5	0	49.5	50.7	0	142	145	0	27	27
2025	10	26	17	40	0	27.5	-1.5	0.947	0.5	0.5	0	49	49.9	0	142	144	0	28	28
2025	10	26	17	50	0	28	-1.7	0.948	0.5	0.5	0	49	50.7	0	142	145	0	28	27
2025	10	26	18	0	0	26.8	-2.1	0.948	0.5	0.5	0	49.9	50.7	0	143	146	0	27	28
2025	10	26	18	10	0	27.1	-1.6	0.948	0.4	0.3	0	49.9	50.3	0	143	145	0	27	28
2025	10	26	18	20	0	27.3	-1.8	0.948	0.5	0.4	0	49.9	50.7	0	143	145	0	27	27
2025	10	26	18	30	0	26.6	-2.2	0.948	0.5	0.4	0	50.3	51.2	0	144	146	0	27	27
2025	10	26	18	40	0	27.5	-1.7	0.948	0.4	0.3	0	49.5	50.3	0	142	144	0	27	27
2025	10	26	18	50	0	26.6	-0.5	0.948	0.5	0.4	0	50.3	51.6	0	144	147	0	27	27
2025	10	26	19	0	0	28.2	-1.5	0.948	0.3	0.2	0	50.3	51.6	0	144	147	0	27	27
2025	10	26	19	10	0	26.5	-0.9	0.948	0.5	0.4	0	50.3	51.2	0	144	147	0	27	28
2025	10	26	19	20	0	26.9	-0.9	0.947	0.5	0.4	0	50.7	51.6	0	145	148	0	27	28
2025	10	26	19	30	0	26.2	-1.8	0.948	0.5	0.5	0	50.7	51.2	0	145	147	0	27	28
2025	10	26	19	40	0	26.1	-2.3	0.947	0.5	0.5	0	50.3	52	0	145	148	0	28	27
2025	10	26	19	50	0	26.2	-0.5	0.947	0.5	0.4	0	50.7	51.6	0	145	148	0	27	28
2025	10	26	20	0	0	26.1	-2.7	0.947	0.5	0.4	0	50.7	52	0	145	148	0	27	27
2025	10	26	20	10	0	26.1	-2.1	0.947	0.5	0.4	0	50.3	51.6	0	145	148	0	28	28
2025	10	26	20	20	0	26.2	-2	0.947	0.5	0.4	0	51.2	52	0	145	148	0	26	27
2025	10	26	20	30	0	27.8	-2.2	0.946	0.5	0.4	0	50.7	52	0	145	148	0	27	27
2025	10	26	20	40	0	26.1	-0.7	0.946	0.5	0.4	0	51.2	52	0	146	149	0	27	28
2025	10	26	20	50	0	27.4	-2.2	0.946	0.4	0.3	0	51.2	52	0	146	148	0	27	27
2025	10	26	21	0	0	26.6	-1.4	0.946	0.4	0.3	0	51.2	52	0	146	149	0	27	28
2025	10	26	21	10	0	26.5	-1.9	0.946	0.5	0.4	0	51.2	52	0	146	149	0	27	28
2025	10	26	21	20	0	27.8	-1.6	0.946	0.5	0.5	0	50.7	52.5	0	146	149	0	28	27
2025	10	26	21	30	0	26.4	-1	0.946	0.5	0.4	0	51.2	52.5	0	146	150	0	27	28
2025	10	26	21	40	0	27.4	-2.1	0.946	0.5	0.4	0	51.2	52.9	0	146	150	0	27	27
2025	10	26	21	50	0	26.8	-2.1	0.946	0.5	0.4	0	51.2	52	0	146	149	0	27	28
2025	10	26	22	0	0	26.2	-2.5	0.945	0.3	0.2	0	51.2	52.5	0	147	150	0	28	28
2025	10	26	22	10	0	27.1	-0.9	0.945	0.5	0.5	0	51.2	52.5	0	146	150	0	27	28
2025	10	26	22	20	0	26.7	-1.2	0.945	0.4	0.3	0	51.2	52.5	0	147	150	0	28	28
2025	10	26	22	30	0	26	-1.8	0.945	0.5	0.5	0	51.6	52.5	0	147	150	0	27	28
2025	10	26	22	40	0	25.8	-2.6	0.945	0.5	0.4	0	51.2	52.9	0	146	150	0	27	27
2025	10	26	22	50	0	26.7	-1.8	0.945	0.5	0.4	0	51.2	52.5	0	147	150	0	28	28
2025	10	26	23	0	0	27.1	-1.7	0.945	0.5	0.5	0	51.6	52.9	0	147	150	0	27	27
2025	10	26	23	10	0	26.5	-0.7	0.945	0.5	0.4	0	51.2	52.9	0	147	151	0	28	28
2025	10	26	23	20	0	25.7	-2.6	0.945	0.5	0.5	0	51.6	52.9	0	147	151	0	27	28
2025	10	26	23	30	0	26.1	-1.4	0.945	0.5	0.4	0	51.6	52.5	0	147	150	0	27	28
2025	10	26	23	40	0	26.7	-1.3	0.945	0.5	0.4	0	51.6	52.5	0	147	150	0	27	28
2025	10	26	23	50	0	27.2	-1.5	0.945	0.5	0.4	0	51.2	52.9	0	147	150	0	28	27
2025	10	27	0	0	0	26.7	-1.4	0.945	0.5	0.4	0	51.6	52.9	0	147	151	0	27	28

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	27	0	10	0	27.2	-1.1	0.945	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	27	0	20	0	26.7	-1.3	0.945	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	27	0	30	0	27.1	-2.5	0.945	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	27	0	40	0	27.4	-1.4	0.944	0.5	0.5	0	50.7	52.5	0	146	150	0	28	28
2025	10	27	0	50	0	26.2	-2.6	0.944	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	27	1	0	0	26.4	-1.1	0.944	0.5	0.4	0	51.2	52.9	0	146	151	0	27	28
2025	10	27	1	10	0	26.3	-1	0.945	0.5	0.4	0	50.7	52.9	0	146	151	0	28	28
2025	10	27	1	20	0	27.4	-1.6	0.944	0.4	0.3	0	50.7	52.5	0	146	150	0	28	28
2025	10	27	1	30	0	24.8	-1.1	0.944	0.5	0.5	0	51.2	52.9	0	146	150	0	27	27
2025	10	27	1	40	0	26.3	-1.2	0.944	0.5	0.5	0	51.2	52.9	0	146	150	0	27	27
2025	10	27	1	50	0	26.4	-1.4	0.944	0.5	0.4	0	51.2	52.5	0	146	151	0	27	29
2025	10	27	2	0	0	26.9	-0.8	0.944	0.5	0.4	0	50.7	52.9	0	146	150	0	28	27
2025	10	27	2	10	0	27.9	-1.2	0.944	0.5	0.5	0	50.7	52.9	0	146	150	0	28	27
2025	10	27	2	20	0	26.6	-2.6	0.944	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	27	2	30	0	26.1	-3.1	0.944	0.4	0.3	0	51.2	53.3	0	147	151	0	28	27
2025	10	27	2	40	0	26.7	-0.6	0.944	0.5	0.4	0	51.6	52.9	0	147	151	0	27	28
2025	10	27	2	50	0	27.6	-3	0.944	0.5	0.5	0	51.2	52.5	0	146	150	0	27	28
2025	10	27	3	0	0	25.7	-1.2	0.944	0.5	0.4	0	51.6	52.9	0	147	151	0	27	28
2025	10	27	3	10	0	26.4	-0.8	0.944	0.5	0.4	0	50.7	53.3	0	146	151	0	28	27
2025	10	27	3	20	0	27.1	-1.8	0.944	0.5	0.5	0	51.2	52.5	0	146	150	0	27	28
2025	10	27	3	30	0	26	-1	0.944	0.5	0.4	0	50.7	52.9	0	146	151	0	28	28
2025	10	27	3	40	0	27.1	-1.8	0.944	0.5	0.4	0	51.6	52.5	0	146	150	0	26	28
2025	10	27	3	50	0	26.1	-2.1	0.944	0.5	0.4	0	51.2	52.5	0	147	150	0	28	28
2025	10	27	4	0	0	27.3	-1.7	0.944	0.5	0.4	0	52	52.9	0	148	151	0	27	28
2025	10	27	4	10	0	25.9	-2.2	0.944	0.5	0.4	0	52	52.5	0	148	150	0	27	28
2025	10	27	4	20	0	27.5	-1.7	0.944	0.5	0.5	0	52	52.5	0	148	150	0	27	28
2025	10	27	4	30	0	27.2	-2.9	0.944	0.5	0.4	0	51.6	52	0	147	149	0	27	28
2025	10	27	4	40	0	26.3	-2.5	0.944	0.5	0.4	0	52	52.9	0	148	151	0	27	28
2025	10	27	4	50	0	26.6	-1.7	0.944	0.4	0.3	0	51.6	53.3	0	147	151	0	27	27
2025	10	27	5	0	0	26.7	-2.2	0.944	0.5	0.5	0	51.6	52.9	0	147	151	0	27	28
2025	10	27	5	10	0	26.6	-2.3	0.944	0.4	0.3	0	51.6	52.5	0	147	150	0	27	28
2025	10	27	5	20	0	25.5	-1	0.944	0.5	0.4	0	51.2	52.9	0	147	151	0	28	28
2025	10	27	5	30	0	27	-2.1	0.944	0.4	0.3	0	52.5	52.5	0	149	150	0	27	28
2025	10	27	5	40	0	26.6	-1.7	0.944	0.5	0.4	0	52	52.9	0	149	150	0	28	27
2025	10	27	5	50	0	26.9	-1.5	0.944	0.5	0.4	0	52.5	52.5	0	149	151	0	27	29
2025	10	27	6	0	0	25.6	-2	0.944	0.5	0.4	0	52.5	53.3	0	149	151	0	27	27
2025	10	27	6	10	0	26.4	-1.7	0.944	0.6	0.5	0	51.6	52.9	0	148	150	0	28	27
2025	10	27	6	20	0	26.3	-2	0.944	0.5	0.5	0	52	52.5	0	148	150	0	27	28
2025	10	27	6	30	0	26.8	-1.7	0.944	0.5	0.4	0	52	52.5	0	149	150	0	28	28
2025	10	27	6	40	0	27.7	-2.6	0.944	0.4	0.3	0	51.6	52	0	148	149	0	28	28
2025	10	27	6	50	0	27.3	-2.7	0.945	0.5	0.4	0	51.6	52.5	0	148	150	0	28	28
2025	10	27	7	0	0	26.5	-1.4	0.944	0.6	0.5	0	52	52.5	0	148	150	0	27	28
2025	10	27	7	10	0	26.2	-2.1	0.945	0.5	0.5	0	51.6	53.3	0	148	151	0	28	27
2025	10	27	7	20	0	26.3	-1.6	0.945	0.5	0.5	0	52	52.5	0	148	150	0	27	28
2025	10	27	7	30	0	26.3	-2.1	0.945	0.5	0.4	0	51.6	52	0	147	149	0	27	28
2025	10	27	7	40	0	27.9	-1.8	0.945	0.4	0.3	0	51.2	51.6	0	146	149	0	27	29
2025	10	27	7	50	0	27.5	-1.9	0.945	0.5	0.5	0	51.2	51.6	0	146	148	0	27	28
2025	10	27	8	0	0	26.2	-1.6	0.946	0.5	0.4	0	51.6	51.6	0	147	148	0	27	28

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	27	8	10	0	26.2	-1.8	0.946	0.5	0.5	0	51.2	51.6	0	147	148	0	28	28
2025	10	27	8	20	0	26.7	-1.8	0.946	0.4	0.3	0	51.2	52	0	146	149	0	27	28
2025	10	27	8	30	0	26.5	-1.3	0.946	0.5	0.4	0	50.7	51.6	0	146	148	0	28	28
2025	10	27	8	40	0	26.9	-2	0.946	0.5	0.4	0	50.7	51.2	0	145	147	0	27	28
2025	10	27	8	50	0	26.3	-1.4	0.946	0.5	0.4	0	50.7	52	0	146	149	0	28	28
2025	10	27	9	0	0	26.3	-1.3	0.947	0.5	0.5	0	49.9	50.7	0	144	146	0	28	28
2025	10	27	9	10	0	27	-1.4	0.947	0.5	0.5	0	49.9	50.7	0	144	146	0	28	28
2025	10	27	9	20	0	26.8	-1.7	0.947	0.6	0.5	0	49.9	50.3	0	143	145	0	27	28
2025	10	27	9	30	0	25.8	-0.9	0.947	0.5	0.5	0	49.9	50.7	0	143	146	0	27	28
2025	10	27	9	40	0	26.3	-2.2	0.947	0.5	0.4	0	49.5	50.3	0	143	145	0	28	28
2025	10	27	9	50	0	27.1	-1.7	0.947	0.4	0.3	0	49.5	49.9	0	142	144	0	27	28
2025	10	27	10	0	0	25.9	-2.5	0.947	0.4	0.3	0	49	50.3	0	142	145	0	28	28
2025	10	27	10	10	0	26.9	-1.8	0.947	0.5	0.4	0	49.5	50.3	0	142	145	0	27	28
2025	10	27	10	20	0	27.6	-2.1	0.947	0.5	0.4	0	48.6	49.9	0	141	143	0	28	27
2025	10	27	10	30	0	26.7	-2.9	0.946	0.5	0.5	0	49.5	49.9	0	142	144	0	27	28
2025	10	27	10	40	0	26.6	-1.3	0.946	0.5	0.4	0	49.5	50.3	0	143	145	0	28	28
2025	10	27	10	50	0	26.8	-1.7	0.946	0.5	0.4	0	49	49.9	0	142	144	0	28	28
2025	10	27	11	0	0	26.9	-2.3	0.946	0.5	0.4	0	49.5	49.9	0	142	144	0	27	28
2025	10	27	11	10	0	25.9	-1.6	0.946	0.6	0.5	0	49.5	50.3	0	143	145	0	28	28
2025	10	27	11	20	0	26.4	-2.5	0.945	0.6	0.5	0	48.2	49.5	0	140	143	0	28	28
2025	10	27	11	30	0	26.7	-1.9	0.946	0.5	0.4	0	49	49.9	0	142	144	0	28	28
2025	10	27	11	40	0	27.3	-2.3	0.945	0.5	0.5	0	48.2	49.5	0	140	143	0	28	28
2025	10	27	11	50	0	26.5	-1.7	0.945	0.5	0.4	0	49	49.9	0	142	144	0	28	28
2025	10	27	12	0	0	26.3	-2	0.945	0.5	0.4	0	49	50.3	0	142	145	0	28	28
2025	10	27	12	10	0	26.6	-2.5	0.945	0.6	0.5	0	49.5	49.9	0	142	144	0	27	28
2025	10	27	12	20	0	26.8	-2	0.945	0.5	0.4	0	49.9	50.3	0	143	145	0	27	28
2025	10	27	12	30	0	25.8	-2.1	0.945	0.4	0.3	0	49.5	50.3	0	143	145	0	28	28
2025	10	27	12	40	0	26.3	-2	0.945	0.5	0.4	0	49	50.3	0	142	144	0	28	27
2025	10	27	12	50	0	26.1	-1.7	0.945	0.5	0.4	0	49	50.3	0	142	144	0	28	27
2025	10	27	13	0	0	26.4	-2.4	0.945	0.5	0.5	0	49	49.9	0	141	144	0	27	28
2025	10	27	13	10	0	27.2	-1.6	0.945	0.5	0.4	0	49.5	50.7	0	143	145	0	28	27
2025	10	27	13	20	0	26.7	-2.2	0.945	0.4	0.3	0	49.5	50.3	0	142	144	0	27	27
2025	10	27	13	30	0	27	-2	0.945	0.5	0.5	0	49	49.5	0	141	143	0	27	28
2025	10	27	13	40	0	25.6	-1.7	0.945	0.5	0.4	0	49	49.9	0	142	144	0	28	28
2025	10	27	13	50	0	27.1	-2.9	0.945	0.5	0.4	0	48.6	49.9	0	141	144	0	28	28
2025	10	27	14	0	0	26.7	-2	0.945	0.5	0.4	0	48.6	49.9	0	141	144	0	28	28
2025	10	27	14	10	0	26.4	-1.2	0.945	0.5	0.5	0	49	49.9	0	141	144	0	27	28
2025	10	27	14	20	0	26.2	-2.2	0.945	0.5	0.4	0	49	49.9	0	141	143	0	27	27
2025	10	27	14	30	0	26.5	-1.8	0.945	0.5	0.5	0	48.6	49.9	0	141	144	0	28	28
2025	10	27	14	40	0	26.9	-1.3	0.945	0.5	0.4	0	49.5	50.3	0	142	144	0	27	27
2025	10	27	14	50	0	27.4	-2.6	0.945	0.5	0.4	0	49.5	50.3	0	142	145	0	27	28
2025	10	27	15	0	0	26.6	-1.9	0.945	0.5	0.4	0	49.5	50.7	0	142	145	0	27	27
2025	10	27	15	10	0	27.5	-2.1	0.945	0.5	0.5	0	49.5	49.9	0	142	144	0	27	28
2025	10	27	15	20	0	26.1	-1.7	0.945	0.5	0.4	0	49	49.9	0	141	144	0	27	28
2025	10	27	15	30	0	26.4	-1.7	0.945	0.5	0.5	0	49.5	49.9	0	142	144	0	27	28
2025	10	27	15	40	0	26.7	-1.8	0.945	0.5	0.4	0	49.5	49.9	0	142	144	0	27	28
2025	10	27	15	50	0	27.6	-1.7	0.945	0.5	0.4	0	49	49.9	0	141	144	0	27	28
2025	10	27	16	0	0	27.1	-1.7	0.945	0.4	0.3	0	49	49.9	0	141	144	0	27	28

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	27	16	10	0	25.8	-0.4	0.946	0.4	0.3	0	49.9	51.2	0	143	146	0	27	27
2025	10	27	16	20	0	27.2	-2.8	0.946	0.4	0.3	0	49	50.7	0	142	145	0	28	27
2025	10	27	16	30	0	26.6	-1.7	0.946	0.6	0.5	0	49.9	50.3	0	143	145	0	27	28
2025	10	27	16	40	0	26.6	-1.9	0.945	0.5	0.5	0	49.9	51.2	0	143	146	0	27	27
2025	10	27	16	50	0	25.9	-1.7	0.945	0.5	0.4	0	49.5	50.3	0	142	145	0	27	28
2025	10	27	17	0	0	25.9	-2.3	0.945	0.5	0.5	0	49.5	50.3	0	142	145	0	27	28
2025	10	27	17	10	0	27.8	-1.3	0.946	0.5	0.4	0	49.5	50.7	0	142	145	0	27	27
2025	10	27	17	20	0	27.1	-2.5	0.946	0.5	0.5	0	49.5	50.7	0	142	145	0	27	27
2025	10	27	17	30	0	27.4	-1.7	0.946	0.4	0.3	0	49.5	50.3	0	142	145	0	27	28
2025	10	27	17	40	0	26.7	-1.8	0.946	0.6	0.5	0	50.7	50.7	0	144	146	0	26	28
2025	10	27	17	50	0	26.1	-1.8	0.946	0.5	0.4	0	50.3	51.2	0	144	147	0	27	28
2025	10	27	18	0	0	25.7	-1.3	0.946	0.5	0.4	0	49.9	50.7	0	143	146	0	27	28
2025	10	27	18	10	0	27.9	-2	0.946	0.4	0.3	0	49.5	50.7	0	142	145	0	27	27
2025	10	27	18	20	0	27.5	-0.9	0.946	0.5	0.5	0	49.5	50.3	0	142	145	0	27	28
2025	10	27	18	30	0	27	-1.7	0.946	0.5	0.4	0	49.9	51.2	0	143	146	0	27	27
2025	10	27	18	40	0	26.2	-0.9	0.945	0.4	0.3	0	49.9	51.6	0	144	147	0	28	27
2025	10	27	18	50	0	26.6	-2.3	0.946	0.5	0.4	0	49.9	51.6	0	143	147	0	27	27
2025	10	27	19	0	0	26.8	-2.2	0.945	0.5	0.5	0	49.9	51.2	0	143	146	0	27	27
2025	10	27	19	10	0	27.6	-0.6	0.945	0.5	0.4	0	49.9	50.7	0	143	146	0	27	28
2025	10	27	19	20	0	25.9	-1.8	0.945	0.5	0.4	0	50.3	51.2	0	144	147	0	27	28
2025	10	27	19	30	0	26.9	-1.5	0.945	0.5	0.4	0	50.3	51.2	0	144	147	0	27	28
2025	10	27	19	40	0	25.7	-0.8	0.945	0.5	0.5	0	49.9	51.2	0	143	147	0	27	28
2025	10	27	19	50	0	27	-2.1	0.945	0.5	0.4	0	50.3	51.6	0	144	147	0	27	27
2025	10	27	20	0	0	26.2	-1.5	0.945	0.4	0.3	0	50.3	51.2	0	144	147	0	27	28
2025	10	27	20	10	0	27.8	-1.3	0.945	0.3	0.2	0	49.5	51.6	0	143	147	0	28	27
2025	10	27	20	20	0	27.1	-1.7	0.945	0.5	0.4	0	49.9	51.2	0	143	147	0	27	28
2025	10	27	20	30	0	27.4	-0.9	0.945	0.5	0.5	0	50.3	51.2	0	144	147	0	27	28
2025	10	27	20	40	0	26.6	-1.6	0.944	0.5	0.4	0	50.7	52	0	145	148	0	27	27
2025	10	27	20	50	0	27.1	-1.6	0.944	0.5	0.4	0	50.7	52	0	145	148	0	27	27
2025	10	27	21	0	0	27.1	-1.7	0.944	0.5	0.4	0	50.3	51.6	0	144	148	0	27	28
2025	10	27	21	10	0	26.1	-1.7	0.944	0.5	0.4	0	50.3	52	0	145	149	0	28	28
2025	10	27	21	20	0	25.7	-2	0.944	0.5	0.5	0	50.3	52	0	145	149	0	28	28
2025	10	27	21	30	0	26.4	-1.6	0.944	0.5	0.4	0	50.3	52	0	145	149	0	28	28
2025	10	27	21	40	0	26.7	-1.5	0.944	0.4	0.3	0	50.7	52.5	0	145	149	0	27	27
2025	10	27	21	50	0	27.1	-1.1	0.944	0.5	0.4	0	51.2	52.5	0	146	149	0	27	27
2025	10	27	22	0	0	26.1	-1.7	0.944	0.5	0.5	0	50.7	52	0	146	149	0	28	28
2025	10	27	22	10	0	27.2	-1.9	0.944	0.4	0.3	0	50.3	52	0	145	149	0	28	28
2025	10	27	22	20	0	26.3	-0.9	0.944	0.3	0.2	0	50.7	52	0	145	149	0	27	28
2025	10	27	22	30	0	27	-1.7	0.943	0.4	0.3	0	50.3	52.5	0	144	149	0	27	27
2025	10	27	22	40	0	27	-1.2	0.944	0.5	0.4	0	50.7	52	0	145	149	0	27	28
2025	10	27	22	50	0	26.7	-1.3	0.944	0.5	0.4	0	50.7	52	0	145	149	0	27	28
2025	10	27	23	0	0	26.5	-2.5	0.943	0.5	0.4	0	50.3	52	0	145	149	0	28	28
2025	10	27	23	10	0	26.6	-2.6	0.943	0.4	0.3	0	50.7	52	0	145	149	0	27	28
2025	10	27	23	20	0	27.1	-2.2	0.943	0.5	0.4	0	50.3	52	0	145	149	0	28	28
2025	10	27	23	30	0	26.4	-1.6	0.943	0.5	0.4	0	50.7	52	0	145	149	0	27	28
2025	10	27	23	40	0	26.5	-1.7	0.943	0.5	0.4	0	50.7	52	0	145	149	0	27	28
2025	10	27	23	50	0	27.2	-1.7	0.943	0.5	0.4	0	50.7	52.5	0	145	149	0	27	27
2025	10	28	0	0	0	26.6	-2.5	0.943	0.4	0.3	0	50.7	52	0	145	149	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	28	0	10	0	25.5	-1.5	0.943	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	28	0	20	0	26.1	-2.4	0.943	0.5	0.4	0	50.7	52.5	0	146	150	0	28	28
2025	10	28	0	30	0	25.8	-1.3	0.943	0.4	0.3	0	51.2	52.5	0	146	150	0	27	28
2025	10	28	0	40	0	26.6	-1.1	0.943	0.5	0.4	0	51.2	52.9	0	146	150	0	27	27
2025	10	28	0	50	0	26.5	-0.9	0.943	0.5	0.5	0	50.3	52	0	145	149	0	28	28
2025	10	28	1	0	0	26.6	-1	0.943	0.5	0.4	0	50.7	52.5	0	146	150	0	28	28
2025	10	28	1	10	0	26.4	-1.7	0.943	0.5	0.4	0	50.7	52.5	0	145	149	0	27	27
2025	10	28	1	20	0	26.1	-0.8	0.943	0.4	0.3	0	51.6	52.5	0	148	150	0	28	28
2025	10	28	1	30	0	25.9	-1.9	0.943	0.4	0.3	0	52	52.9	0	148	150	0	27	27
2025	10	28	1	40	0	27.8	-2.5	0.943	0.5	0.5	0	51.6	52.5	0	147	149	0	27	27
2025	10	28	1	50	0	26	-2.1	0.943	0.4	0.3	0	51.6	52	0	147	149	0	27	28
2025	10	28	2	0	0	26.6	-1.3	0.943	0.6	0.5	0	52	52.5	0	148	150	0	27	28
2025	10	28	2	10	0	25.5	-1.8	0.943	0.4	0.3	0	51.2	52.5	0	147	150	0	28	28
2025	10	28	2	20	0	27.5	-1.6	0.943	0.5	0.4	0	51.2	52	0	147	149	0	28	28
2025	10	28	2	30	0	26.9	-1.6	0.943	0.5	0.4	0	51.2	52	0	147	149	0	28	28
2025	10	28	2	40	0	27.1	-2.1	0.943	0.3	0.2	0	51.6	52	0	147	149	0	27	28
2025	10	28	2	50	0	27.3	-2.5	0.943	0.5	0.4	0	51.2	52	0	147	149	0	28	28
2025	10	28	3	0	0	26.6	-0.4	0.942	0.3	0.2	0	51.2	52	0	147	149	0	28	28
2025	10	28	3	10	0	26.8	-2.4	0.943	0.5	0.5	0	51.2	52	0	147	149	0	28	28
2025	10	28	3	20	0	26.4	-1.5	0.943	0.5	0.4	0	51.6	51.6	0	147	149	0	27	29
2025	10	28	3	30	0	25.6	-1.8	0.943	0.5	0.5	0	51.6	52.9	0	147	150	0	27	27
2025	10	28	3	40	0	28.2	-2.3	0.943	0.5	0.4	0	51.2	52.5	0	147	150	0	28	28
2025	10	28	3	50	0	27.6	-3	0.943	0.5	0.4	0	51.6	52.5	0	148	150	0	28	28
2025	10	28	4	0	0	27	-2.1	0.943	0.4	0.3	0	52	52.9	0	148	151	0	27	28
2025	10	28	4	10	0	25.5	-2.2	0.943	0.5	0.4	0	52	52	0	148	150	0	27	29
2025	10	28	4	20	0	26.8	-2.6	0.943	0.6	0.5	0	52	53.3	0	148	151	0	27	27
2025	10	28	4	30	0	26.2	-0.6	0.943	0.5	0.5	0	51.6	52.9	0	147	150	0	27	27
2025	10	28	4	40	0	26	-1.3	0.943	0.5	0.5	0	51.2	52.5	0	147	149	0	28	27
2025	10	28	4	50	0	26.3	-0.9	0.943	0.5	0.4	0	51.2	52.5	0	147	150	0	28	28
2025	10	28	5	0	0	27.2	-1.8	0.943	0.5	0.5	0	51.2	52.5	0	147	149	0	28	27
2025	10	28	5	10	0	27.2	-0.5	0.943	0.4	0.3	0	51.6	52.9	0	147	150	0	27	27
2025	10	28	5	20	0	26.6	-1	0.943	0.5	0.5	0	51.2	52	0	146	149	0	27	28
2025	10	28	5	30	0	26.3	-2.4	0.943	0.5	0.5	0	50.7	52.5	0	146	149	0	28	27
2025	10	28	5	40	0	27.5	-1.3	0.943	0.4	0.3	0	50.7	52.5	0	146	150	0	28	28
2025	10	28	5	50	0	27.2	-1.6	0.943	0.5	0.4	0	51.2	52.5	0	146	150	0	27	28
2025	10	28	6	0	0	27.6	-1.2	0.943	0.5	0.4	0	50.7	52.5	0	146	149	0	28	27
2025	10	28	6	10	0	27	-1.9	0.943	0.4	0.3	0	51.2	52	0	146	149	0	27	28
2025	10	28	6	20	0	27	-0.6	0.943	0.4	0.3	0	50.7	52	0	146	149	0	28	28
2025	10	28	6	30	0	25.5	-0.4	0.943	0.5	0.4	0	51.6	52.5	0	147	150	0	27	28
2025	10	28	6	40	0	25.5	-2.1	0.943	0.5	0.4	0	50.7	52.5	0	146	150	0	28	28
2025	10	28	6	50	0	26.9	-2.6	0.943	0.5	0.4	0	51.2	52.5	0	146	150	0	27	28
2025	10	28	7	0	0	27.5	-2.1	0.943	0.5	0.4	0	50.7	52.5	0	146	150	0	28	28
2025	10	28	7	10	0	26.5	-1.9	0.943	0.4	0.3	0	50.7	52.5	0	146	150	0	28	28
2025	10	28	7	20	0	26.9	-1.2	0.943	0.5	0.4	0	50.7	52	0	146	149	0	28	28
2025	10	28	7	30	0	25.8	-0.8	0.943	0.4	0.3	0	50.7	52.5	0	146	150	0	28	28
2025	10	28	7	40	0	26.3	-1.6	0.943	0.5	0.5	0	50.7	52	0	146	149	0	28	28
2025	10	28	7	50	0	26.2	-1.7	0.943	0.4	0.3	0	50.7	52	0	145	149	0	27	28
2025	10	28	8	0	0	25.7	-0.9	0.943	0.5	0.4	0	50.3	51.2	0	144	148	0	27	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	28	8	10	0	27	-1.4	0.943	0.4	0.3	0	49.9	51.6	0	144	148	0	28	28
2025	10	28	8	20	0	25.7	-1.4	0.943	0.5	0.5	0	49.9	51.6	0	144	148	0	28	28
2025	10	28	8	30	0	26.4	-1.7	0.943	0.4	0.3	0	50.3	51.6	0	144	148	0	27	28
2025	10	28	8	40	0	26.6	-2	0.943	0.4	0.3	0	50.3	51.2	0	144	147	0	27	28
2025	10	28	8	50	0	27	-2.7	0.943	0.5	0.4	0	49.5	50.7	0	143	146	0	28	28
2025	10	28	9	0	0	27.7	-2	0.943	0.5	0.4	0	49	51.2	0	142	146	0	28	27
2025	10	28	9	10	0	26.7	-1	0.943	0.5	0.4	0	49	50.7	0	142	146	0	28	28
2025	10	28	9	20	0	25.7	-1.3	0.943	0.5	0.5	0	49	50.3	0	141	145	0	27	28
2025	10	28	9	30	0	26.7	-2.5	0.943	0.5	0.4	0	49.5	50.7	0	143	146	0	28	28
2025	10	28	9	40	0	26	-1.6	0.943	0.5	0.4	0	49.5	50.7	0	143	146	0	28	28
2025	10	28	9	50	0	26.2	-1.9	0.943	0.5	0.4	0	49	50.7	0	142	146	0	28	28
2025	10	28	10	0	0	26.7	-1.7	0.943	0.5	0.4	0	49	49.9	0	142	145	0	28	29
2025	10	28	10	10	0	26.7	-1.3	0.943	0.5	0.5	0	48.6	49.9	0	141	144	0	28	28
2025	10	28	10	20	0	26.4	-1.8	0.944	0.5	0.5	0	49	50.3	0	142	145	0	28	28
2025	10	28	10	30	0	26.6	-1.5	0.943	0.5	0.5	0	49	50.3	0	141	144	0	27	27
2025	10	28	10	40	0	25.6	-1.5	0.944	0.4	0.3	0	49.9	50.7	0	143	146	0	27	28
2025	10	28	10	50	0	26.2	-1.6	0.944	0.5	0.4	0	50.7	51.2	0	145	147	0	27	28
2025	10	28	11	0	0	27	-1.9	0.944	0.5	0.5	0	49	50.3	0	142	145	0	28	28
2025	10	28	11	10	0	26.3	-1.8	0.944	0.5	0.4	0	48.2	49.5	0	140	143	0	28	28
2025	10	28	11	20	0	26.8	-1.5	0.944	0.4	0.3	0	47.7	49.5	0	139	143	0	28	28
2025	10	28	11	30	0	26.5	-1.4	0.944	0.5	0.4	0	48.6	49.9	0	141	144	0	28	28
2025	10	28	11	40	0	27.5	-1.6	0.944	0.5	0.4	0	48.6	49.5	0	140	143	0	27	28
2025	10	28	11	50	0	26.1	-1.5	0.944	0.4	0.3	0	48.2	49.5	0	139	143	0	27	28
2025	10	28	12	0	0	25.8	-1	0.944	0.5	0.4	0	47.3	49	0	138	141	0	28	27
2025	10	28	12	10	0	26.6	-2.3	0.944	0.5	0.4	0	47.3	48.6	0	138	141	0	28	28
2025	10	28	12	20	0	26.2	-2.2	0.944	0.5	0.4	0	47.7	48.6	0	138	141	0	27	28
2025	10	28	12	30	0	27	-3.2	0.944	0.4	0.3	0	47.3	49	0	138	141	0	28	27
2025	10	28	12	40	0	26.5	-1.2	0.944	0.5	0.5	0	47.7	48.6	0	138	141	0	27	28
2025	10	28	12	50	0	27	-2.5	0.944	0.6	0.5	0	47.3	48.6	0	137	141	0	27	28
2025	10	28	13	0	0	26.6	-3	0.944	0.5	0.4	0	47.3	48.6	0	138	141	0	28	28
2025	10	28	13	10	0	26.2	-2.5	0.945	0.5	0.4	0	46.9	48.6	0	137	141	0	28	28
2025	10	28	13	20	0	27.9	-2.4	0.945	0.5	0.4	0	47.3	48.2	0	137	140	0	27	28
2025	10	28	13	30	0	27.6	-2.3	0.945	0.5	0.4	0	47.3	48.6	0	137	141	0	27	28
2025	10	28	13	40	0	26.8	-1.5	0.945	0.5	0.5	0	47.3	48.6	0	138	141	0	28	28
2025	10	28	13	50	0	26.8	-0.7	0.945	0.4	0.3	0	47.7	49	0	138	141	0	27	27
2025	10	28	14	0	0	26.3	-1.3	0.945	0.4	0.3	0	47.3	48.6	0	138	141	0	28	28
2025	10	28	14	10	0	27.9	-2.2	0.945	0.5	0.4	0	47.7	49	0	138	141	0	27	27
2025	10	28	14	20	0	26.4	-2.2	0.945	0.4	0.3	0	47.3	48.2	0	137	140	0	27	28
2025	10	28	14	30	0	26.4	-0.9	0.945	0.4	0.3	0	47.7	48.6	0	138	141	0	27	28
2025	10	28	14	40	0	26.8	-2.9	0.945	0.5	0.4	0	47.7	48.6	0	138	141	0	27	28
2025	10	28	14	50	0	26.9	-0.9	0.945	0.5	0.4	0	48.2	49	0	139	142	0	27	28
2025	10	28	15	0	0	27.3	-1.6	0.945	0.5	0.5	0	47.7	49	0	138	141	0	27	27
2025	10	28	15	10	0	26.8	-1.9	0.945	0.4	0.3	0	48.2	49.5	0	139	142	0	27	27
2025	10	28	15	20	0	26.9	-1.4	0.945	0.5	0.4	0	47.7	48.6	0	138	141	0	27	28
2025	10	28	15	30	0	26.2	-1.7	0.945	0.5	0.4	0	47.7	49.5	0	138	142	0	27	27
2025	10	28	15	40	0	26.3	-1.9	0.945	0.5	0.5	0	47.7	49	0	138	142	0	27	28
2025	10	28	15	50	0	26.9	-1.4	0.945	0.4	0.3	0	47.7	49	0	138	142	0	27	28
2025	10	28	16	0	0	27.6	-1.6	0.945	0.5	0.5	0	47.7	49.5	0	139	142	0	28	27

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	28	16	10	0	27.3	-1.1	0.945	0.6	0.5	0	48.2	49.5	0	139	142	0	27	27
2025	10	28	16	20	0	27.4	-1.5	0.945	0.5	0.4	0	47.7	48.6	0	138	141	0	27	28
2025	10	28	16	30	0	26.8	-1.6	0.945	0.5	0.4	0	47.7	49	0	138	142	0	27	28
2025	10	28	16	40	0	26.5	-1.3	0.945	0.5	0.4	0	48.2	49.5	0	139	142	0	27	27
2025	10	28	16	50	0	26.7	-1.7	0.945	0.4	0.3	0	47.7	49.5	0	138	142	0	27	27
2025	10	28	17	0	0	27.1	-2.6	0.945	0.4	0.3	0	48.2	49.9	0	139	143	0	27	27
2025	10	28	17	10	0	27.1	-1.3	0.945	0.4	0.3	0	47.7	49	0	138	142	0	27	28
2025	10	28	17	20	0	26.9	-1.8	0.945	0.5	0.4	0	47.7	49.5	0	138	142	0	27	27
2025	10	28	17	30	0	26.6	-1.7	0.945	0.5	0.4	0	47.7	49	0	138	142	0	27	28
2025	10	28	17	40	0	25.8	-1.1	0.945	0.5	0.5	0	47.7	49.5	0	138	143	0	27	28
2025	10	28	17	50	0	25.9	-0.7	0.945	0.5	0.4	0	47.7	49.5	0	138	142	0	27	27
2025	10	28	18	0	0	26.9	-1.5	0.945	0.4	0.3	0	47.7	49.5	0	138	143	0	27	28
2025	10	28	18	10	0	25.8	-1.3	0.945	0.5	0.4	0	47.7	49	0	138	142	0	27	28
2025	10	28	18	20	0	26	-1.1	0.945	0.4	0.3	0	48.6	49.9	0	140	143	0	27	27
2025	10	28	18	30	0	27	-0.9	0.945	0.5	0.4	0	48.2	49.5	0	139	143	0	27	28
2025	10	28	18	40	0	26	-1.9	0.945	0.5	0.5	0	48.2	49.9	0	139	143	0	27	27
2025	10	28	18	50	0	26.9	-2.2	0.945	0.6	0.5	0	48.2	49.9	0	139	143	0	27	27
2025	10	28	19	0	0	27.7	-2.3	0.945	0.5	0.4	0	48.6	50.3	0	140	144	0	27	27
2025	10	28	19	10	0	27.2	-2	0.945	0.4	0.3	0	48.2	49.9	0	139	144	0	27	28
2025	10	28	19	20	0	25.5	-1.6	0.945	0.5	0.5	0	49.5	50.7	0	142	146	0	27	28
2025	10	28	19	30	0	27.2	-1	0.945	0.5	0.4	0	49	50.3	0	141	145	0	27	28
2025	10	28	19	40	0	26.4	-1.5	0.945	0.5	0.5	0	49	51.2	0	141	146	0	27	27
2025	10	28	19	50	0	26.3	-1.4	0.945	0.5	0.4	0	49.5	50.7	0	142	146	0	27	28
2025	10	28	20	0	0	25.5	-0.9	0.945	0.5	0.4	0	49.5	50.7	0	142	146	0	27	28
2025	10	28	20	10	0	26.4	-2.6	0.944	0.5	0.5	0	49.9	51.2	0	142	147	0	26	28
2025	10	28	20	20	0	26.1	-2.1	0.944	0.5	0.4	0	49.5	51.6	0	142	147	0	27	27
2025	10	28	20	30	0	27.7	-1.7	0.944	0.6	0.5	0	49.5	50.7	0	142	146	0	27	28
2025	10	28	20	40	0	26.7	-0.5	0.944	0.4	0.3	0	49.9	51.2	0	143	147	0	27	28
2025	10	28	20	50	0	27.9	-2.2	0.944	0.5	0.4	0	49.5	50.7	0	142	146	0	27	28
2025	10	28	21	0	0	26	-2.2	0.944	0.5	0.5	0	49.9	51.6	0	143	147	0	27	27
2025	10	28	21	10	0	25.8	-0.2	0.944	0.5	0.4	0	49.5	51.6	0	142	148	0	27	28
2025	10	28	21	20	0	26.3	-1.8	0.944	0.5	0.5	0	49.9	51.6	0	143	148	0	27	28
2025	10	28	21	30	0	27	-2.3	0.944	0.5	0.4	0	49.9	51.6	0	143	147	0	27	27
2025	10	28	21	40	0	26.2	-2.2	0.944	0.4	0.3	0	49.5	51.6	0	143	148	0	28	28
2025	10	28	21	50	0	26.6	-1.6	0.944	0.5	0.5	0	49.5	52	0	142	148	0	27	27
2025	10	28	22	0	0	25.6	-2.2	0.944	0.5	0.5	0	49	51.6	0	142	148	0	28	28
2025	10	28	22	10	0	25.9	-1.7	0.944	0.5	0.4	0	49.5	51.6	0	143	148	0	28	28
2025	10	28	22	20	0	25.5	-2.2	0.944	0.5	0.5	0	49.5	51.6	0	143	148	0	28	28
2025	10	28	22	30	0	26.6	-2.7	0.944	0.5	0.4	0	49.9	51.6	0	143	148	0	27	28
2025	10	28	22	40	0	25.9	-1.9	0.944	0.5	0.4	0	49.9	51.6	0	143	148	0	27	28
2025	10	28	22	50	0	26.8	-1.8	0.943	0.4	0.3	0	49.9	51.6	0	143	148	0	27	28
2025	10	28	23	0	0	26.6	-2.3	0.943	0.5	0.4	0	49.5	52	0	143	148	0	28	27
2025	10	28	23	10	0	26.7	-1.6	0.944	0.5	0.5	0	50.3	51.6	0	144	148	0	27	28
2025	10	28	23	20	0	25.7	-1.3	0.943	0.5	0.4	0	50.3	52.5	0	144	149	0	27	27
2025	10	28	23	30	0	26.6	-0.4	0.944	0.5	0.4	0	49.9	52	0	144	149	0	28	28
2025	10	28	23	40	0	26.1	-1.9	0.943	0.5	0.5	0	50.3	52.5	0	144	149	0	27	27
2025	10	28	23	50	0	26.3	-1.8	0.943	0.5	0.5	0	49.9	52	0	144	149	0	28	28
2025	10	29	0	0	0	26.5	-1.2	0.943	0.4	0.3	0	49.9	51.6	0	143	148	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	29	0	10	0	27	-1.6	0.943	0.5	0.4	0	49.9	51.6	0	144	148	0	28	28
2025	10	29	0	20	0	26.3	-1.3	0.943	0.3	0.2	0	49.9	52	0	143	149	0	27	28
2025	10	29	0	30	0	27.7	-2.2	0.943	0.5	0.4	0	50.3	51.6	0	144	148	0	27	28
2025	10	29	0	40	0	25.4	-0.9	0.943	0.5	0.4	0	50.7	52	0	145	149	0	27	28
2025	10	29	0	50	0	27.1	-2.1	0.943	0.5	0.4	0	50.7	51.6	0	145	148	0	27	28
2025	10	29	1	0	0	26.7	-1.6	0.943	0.5	0.5	0	50.3	52.5	0	145	149	0	28	27
2025	10	29	1	10	0	27.4	-1.3	0.943	0.5	0.4	0	50.3	52	0	144	148	0	27	27
2025	10	29	1	20	0	27	-1.7	0.943	0.6	0.5	0	50.3	52	0	145	149	0	28	28
2025	10	29	1	30	0	26.6	-3	0.943	0.5	0.4	0	49.9	51.6	0	144	148	0	28	28
2025	10	29	1	40	0	27.2	-2.1	0.943	0.4	0.3	0	50.3	51.6	0	144	148	0	27	28
2025	10	29	1	50	0	27.6	-2.1	0.943	0.4	0.3	0	49.9	51.2	0	144	148	0	28	29
2025	10	29	2	0	0	26.1	-1.8	0.943	0.5	0.5	0	49.9	52	0	144	148	0	28	27
2025	10	29	2	10	0	26.8	-1.7	0.943	0.5	0.4	0	50.3	51.6	0	144	148	0	27	28
2025	10	29	2	20	0	27	-1.9	0.943	0.5	0.5	0	50.3	51.6	0	144	148	0	27	28
2025	10	29	2	30	0	26.6	-2.1	0.943	0.5	0.4	0	49.9	51.2	0	144	148	0	28	29
2025	10	29	2	40	0	26.4	-0.9	0.943	0.4	0.3	0	49.9	51.6	0	143	148	0	27	28
2025	10	29	2	50	0	26.3	-1.6	0.943	0.4	0.3	0	49.9	51.6	0	144	148	0	28	28
2025	10	29	3	0	0	26.9	-2	0.943	0.5	0.4	0	49.9	51.6	0	143	148	0	27	28
2025	10	29	3	10	0	25.9	-1.2	0.943	0.4	0.3	0	49.9	52	0	143	148	0	27	27
2025	10	29	3	20	0	27.5	-1.3	0.943	0.5	0.5	0	49.9	51.6	0	143	148	0	27	28
2025	10	29	3	30	0	26	-1.6	0.943	0.5	0.4	0	49.9	51.6	0	143	148	0	27	28
2025	10	29	3	40	0	27	-1.7	0.943	0.5	0.4	0	49.5	51.6	0	143	148	0	28	28
2025	10	29	3	50	0	25.9	-2	0.943	0.5	0.5	0	49.5	51.6	0	143	148	0	28	28
2025	10	29	4	0	0	26.8	-1.7	0.943	0.5	0.4	0	49	51.6	0	142	148	0	28	28
2025	10	29	4	10	0	27.4	-2.3	0.943	0.5	0.4	0	49.5	51.6	0	143	148	0	28	28
2025	10	29	4	20	0	26.7	-2.8	0.943	0.4	0.3	0	49.5	51.2	0	142	147	0	27	28
2025	10	29	4	30	0	26.7	-1.5	0.943	0.5	0.4	0	49.5	51.2	0	142	147	0	27	28
2025	10	29	4	40	0	26.4	-2.3	0.943	0.5	0.4	0	49.5	51.2	0	142	147	0	27	28
2025	10	29	4	50	0	26	-1.9	0.943	0.5	0.4	0	49	51.2	0	142	147	0	28	28
2025	10	29	5	0	0	26.8	-1.7	0.943	0.3	0.2	0	49.5	51.2	0	142	147	0	27	28
2025	10	29	5	10	0	27.1	-2.4	0.943	0.5	0.4	0	49	51.2	0	142	147	0	28	28
2025	10	29	5	20	0	25.9	-1.7	0.943	0.4	0.3	0	49.9	51.6	0	143	148	0	27	28
2025	10	29	5	30	0	25.9	-1.3	0.943	0.5	0.4	0	49.5	51.6	0	143	148	0	28	28
2025	10	29	5	40	0	26.1	-1.5	0.943	0.5	0.5	0	49.9	51.6	0	143	148	0	27	28
2025	10	29	5	50	0	26.9	-2.5	0.943	0.6	0.5	0	49	51.6	0	142	148	0	28	28
2025	10	29	6	0	0	28.2	-2.9	0.944	0.4	0.3	0	49.5	51.6	0	142	147	0	27	27
2025	10	29	6	10	0	26.9	-1.6	0.944	0.5	0.4	0	49	51.6	0	142	148	0	28	28
2025	10	29	6	20	0	25.7	-1.6	0.944	0.5	0.5	0	49.5	51.6	0	143	148	0	28	28
2025	10	29	6	30	0	27.4	-1.3	0.944	0.5	0.5	0	49.5	51.2	0	143	148	0	28	29
2025	10	29	6	40	0	27.1	-2.4	0.944	0.5	0.5	0	49.5	51.2	0	142	147	0	27	28
2025	10	29	6	50	0	25.7	-3	0.944	0.5	0.4	0	47.7	51.2	0	139	147	0	28	28
2025	10	29	7	0	0	26.2	-1.2	0.945	0.5	0.4	0	49	51.2	0	143	147	0	29	28
2025	10	29	7	10	0	26.5	-2.1	0.945	0.4	0.3	0	49	51.2	0	142	147	0	28	28
2025	10	29	7	20	0	26.7	-2.5	0.945	0.3	0.2	0	48.6	51.2	0	142	147	0	29	28
2025	10	29	7	30	0	26.8	-1.6	0.946	0.5	0.4	0	49	51.6	0	141	147	0	27	27
2025	10	29	7	40	0	26.1	-1.7	0.946	0.4	0.3	0	49	50.7	0	141	146	0	27	28
2025	10	29	7	50	0	26.3	-0.8	0.946	0.4	0.3	0	48.6	50.7	0	140	146	0	27	28
2025	10	29	8	0	0	26.7	-1.7	0.946	0.4	0.3	0	47.7	50.3	0	139	145	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	29	8	10	0	25.5	-1.7	0.946	0.4	0.3	0	48.2	50.3	0	140	145	0	28	28
2025	10	29	8	20	0	25.7	-1.5	0.946	0.5	0.4	0	48.2	49.9	0	140	145	0	28	29
2025	10	29	8	30	0	25.5	-1.1	0.946	0.5	0.5	0	48.2	49.9	0	139	144	0	27	28
2025	10	29	8	40	0	27	-2.1	0.946	0.5	0.5	0	47.3	49.5	0	138	143	0	28	28
2025	10	29	8	50	0	26.3	-1.9	0.947	0.5	0.5	0	46.9	49	0	137	142	0	28	28
2025	10	29	9	0	0	27.5	-1.3	0.947	0.5	0.4	0	46	48.2	0	135	141	0	28	29
2025	10	29	9	10	0	24.9	-2.2	0.947	0.4	0.3	0	46	48.6	0	135	141	0	28	28
2025	10	29	9	20	0	27.6	-1.9	0.947	0.5	0.5	0	46	47.7	0	134	140	0	27	29
2025	10	29	9	30	0	27	-1.3	0.947	0.4	0.3	0	45.6	47.7	0	134	140	0	28	29
2025	10	29	9	40	0	25.1	-1.5	0.947	0.5	0.4	0	46	48.6	0	135	141	0	28	28
2025	10	29	9	50	0	25.9	-1.2	0.947	0.4	0.3	0	46	48.2	0	135	140	0	28	28
2025	10	29	10	0	0	26.4	-2.3	0.947	0.4	0.3	0	45.6	47.3	0	134	139	0	28	29
2025	10	29	10	10	0	27.3	-2.1	0.947	0.5	0.5	0	46.4	48.6	0	136	141	0	28	28
2025	10	29	10	20	0	27.2	-1.8	0.947	0.5	0.4	0	45.6	47.7	0	134	139	0	28	28
2025	10	29	10	30	0	27.4	-1.6	0.947	0.3	0.2	0	45.2	47.7	0	133	139	0	28	28
2025	10	29	10	40	0	25.4	-1.3	0.947	0.5	0.4	0	44.3	46.9	0	131	137	0	28	28
2025	10	29	10	50	0	26.5	-1.7	0.947	0.5	0.4	0	44.3	46	0	130	136	0	27	29
2025	10	29	11	0	0	26.6	-2.1	0.947	0.5	0.4	0	44.3	46.9	0	131	137	0	28	28
2025	10	29	11	10	0	26.3	-1.6	0.947	0.5	0.4	0	45.2	47.7	0	133	139	0	28	28
2025	10	29	11	20	0	26.2	-1.6	0.947	0.5	0.5	0	44.7	46.9	0	132	137	0	28	28
2025	10	29	11	30	0	26.6	-1.7	0.947	0.5	0.4	0	44.3	46.4	0	131	136	0	28	28
2025	10	29	11	40	0	26.2	-1.9	0.947	0.3	0.2	0	43.9	46.4	0	130	136	0	28	28
2025	10	29	11	50	0	25.1	-0.9	0.947	0.4	0.3	0	44.3	46.4	0	130	136	0	27	28
2025	10	29	12	0	0	26.8	-2.2	0.947	0.5	0.4	0	43.4	46	0	129	135	0	28	28
2025	10	29	12	10	0	27.2	-1.6	0.947	0.4	0.3	0	43.4	46	0	129	135	0	28	28
2025	10	29	12	20	0	26.2	-1.9	0.946	0.4	0.3	0	43.9	46.4	0	130	136	0	28	28
2025	10	29	12	30	0	26.4	-1.2	0.945	0.5	0.4	0	44.3	46.4	0	130	136	0	27	28
2025	10	29	12	40	0	26.9	-2	0.945	0.5	0.4	0	43.9	45.6	0	130	135	0	28	29
2025	10	29	12	50	0	26	-2.4	0.946	0.5	0.5	0	43.9	46	0	129	135	0	27	28
2025	10	29	13	0	0	26.4	-1.2	0.946	0.4	0.3	0	44.3	46.4	0	130	136	0	27	28
2025	10	29	13	10	0	26.5	-2.1	0.945	0.5	0.5	0	44.3	46.4	0	130	136	0	27	28
2025	10	29	13	20	0	25.2	-1.3	0.945	0.5	0.4	0	44.3	46.4	0	130	136	0	27	28
2025	10	29	13	30	0	26.3	-0.5	0.945	0.5	0.4	0	44.7	46.9	0	131	137	0	27	28
2025	10	29	13	40	0	26.3	-1	0.945	0.5	0.5	0	44.7	46.9	0	131	136	0	27	27
2025	10	29	13	50	0	26.8	-1.8	0.945	0.4	0.3	0	45.2	48.2	0	133	139	0	28	27
2025	10	29	14	0	0	26.8	-1.7	0.945	0.5	0.4	0	45.2	46.9	0	132	137	0	27	28
2025	10	29	14	10	0	26.7	-2.6	0.945	0.5	0.5	0	45.2	47.3	0	132	138	0	27	28
2025	10	29	14	20	0	27	-1.1	0.945	0.4	0.3	0	44.3	47.3	0	131	137	0	28	27
2025	10	29	14	30	0	27.7	-2.4	0.945	0.5	0.4	0	45.2	47.3	0	132	137	0	27	27
2025	10	29	14	40	0	26.4	-0.4	0.945	0.5	0.4	0	46	47.7	0	134	139	0	27	28
2025	10	29	14	50	0	25.8	-1.4	0.946	0.5	0.4	0	45.6	47.7	0	133	139	0	27	28
2025	10	29	15	0	0	26.5	-1.8	0.946	0.5	0.5	0	45.6	47.3	0	133	138	0	27	28
2025	10	29	15	10	0	26.6	-2.1	0.946	0.5	0.4	0	45.6	47.3	0	133	138	0	27	28
2025	10	29	15	20	0	27.1	-1.4	0.946	0.5	0.4	0	44.7	47.3	0	132	138	0	28	28
2025	10	29	15	30	0	26.4	-2.6	0.946	0.5	0.4	0	44.7	46.9	0	131	137	0	27	28
2025	10	29	15	40	0	26.7	-1.1	0.946	0.4	0.3	0	44.7	46.9	0	132	137	0	28	28
2025	10	29	15	50	0	27.7	-2.2	0.946	0.5	0.5	0	44.7	46.9	0	131	137	0	27	28
2025	10	29	16	0	0	27.4	-1.6	0.946	0.5	0.5	0	44.3	47.3	0	131	137	0	28	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	29	16	10	0	27.1	-3.2	0.946	0.5	0.4	0	45.2	46.9	0	132	137	0	27	28
2025	10	29	16	20	0	26.8	-0.9	0.946	0.4	0.3	0	45.2	47.7	0	132	138	0	27	27
2025	10	29	16	30	0	26.2	-1.7	0.946	0.4	0.3	0	44.7	47.7	0	132	138	0	28	27
2025	10	29	16	40	0	27.1	-1.9	0.946	0.5	0.4	0	45.6	47.7	0	133	139	0	27	28
2025	10	29	16	50	0	27.6	-1.3	0.946	0.5	0.4	0	44.7	47.3	0	132	138	0	28	28
2025	10	29	17	0	0	26.8	-2.4	0.946	0.5	0.4	0	45.6	47.7	0	133	138	0	27	27
2025	10	29	17	10	0	26.5	-2	0.946	0.5	0.4	0	45.6	47.7	0	133	139	0	27	28
2025	10	29	17	20	0	27.6	-1.9	0.946	0.5	0.4	0	45.6	48.2	0	133	139	0	27	27
2025	10	29	17	30	0	25.5	-1.7	0.946	0.6	0.5	0	45.2	47.7	0	132	139	0	27	28
2025	10	29	17	40	0	26.7	-1.5	0.946	0.5	0.4	0	45.2	47.7	0	133	139	0	28	28
2025	10	29	17	50	0	26.5	-2.3	0.947	0.5	0.4	0	45.6	47.7	0	133	139	0	27	28
2025	10	29	18	0	0	27	-1.5	0.947	0.5	0.4	0	45.6	47.3	0	133	139	0	27	29
2025	10	29	18	10	0	27.6	-1.7	0.947	0.5	0.4	0	45.6	48.2	0	133	140	0	27	28
2025	10	29	18	20	0	26.3	-0.8	0.946	0.5	0.4	0	46	48.6	0	134	140	0	27	27
2025	10	29	18	30	0	27.1	-2.7	0.946	0.5	0.4	0	46	48.2	0	134	140	0	27	28
2025	10	29	18	40	0	26.4	-1.3	0.947	0.5	0.4	0	46.4	48.6	0	135	141	0	27	28
2025	10	29	18	50	0	26.8	-2.5	0.947	0.5	0.5	0	48.2	48.6	0	139	141	0	27	28
2025	10	29	19	0	0	27.6	-1.7	0.946	0.4	0.3	0	48.6	49	0	140	142	0	27	28
2025	10	29	19	10	0	26.5	-0.9	0.946	0.5	0.5	0	48.6	49.5	0	140	142	0	27	27
2025	10	29	19	20	0	26.7	-1.5	0.946	0.6	0.5	0	48.6	49.9	0	141	143	0	28	27
2025	10	29	19	30	0	26.5	-1.5	0.946	0.3	0.2	0	49	49.5	0	141	143	0	27	28
2025	10	29	19	40	0	26.1	-0.9	0.946	0.4	0.3	0	49	49.9	0	141	143	0	27	27
2025	10	29	19	50	0	26.1	-0.9	0.946	0.5	0.5	0	49	49.9	0	142	144	0	28	28
2025	10	29	20	0	0	26.8	-1.2	0.946	0.4	0.3	0	49	49.9	0	142	144	0	28	28
2025	10	29	20	10	0	27.4	-1.9	0.946	0.4	0.3	0	49	49.9	0	141	144	0	27	28
2025	10	29	20	20	0	27.1	-0.8	0.946	0.5	0.4	0	49.5	49.9	0	142	144	0	27	28
2025	10	29	20	30	0	27.1	-1.3	0.946	0.5	0.4	0	49.5	50.7	0	142	145	0	27	27
2025	10	29	20	40	0	27.1	-2.1	0.946	0.5	0.5	0	49.5	50.3	0	142	145	0	27	28
2025	10	29	20	50	0	26.3	-2	0.945	0.6	0.5	0	49.9	50.3	0	143	145	0	27	28
2025	10	29	21	0	0	27.5	-1.7	0.945	0.4	0.3	0	49	50.7	0	142	145	0	28	27
2025	10	29	21	10	0	27.4	-1.9	0.945	0.5	0.4	0	49.9	50.3	0	143	145	0	27	28
2025	10	29	21	20	0	26.9	-2.1	0.945	0.5	0.4	0	49.5	51.2	0	143	146	0	28	27
2025	10	29	21	30	0	26.7	-1.7	0.945	0.5	0.4	0	49.5	50.3	0	143	145	0	28	28
2025	10	29	21	40	0	26.1	-0.9	0.945	0.5	0.4	0	50.3	50.7	0	144	146	0	27	28
2025	10	29	21	50	0	26.8	-2	0.944	0.5	0.5	0	49.9	50.7	0	143	146	0	27	28
2025	10	29	22	0	0	26.6	-1.5	0.944	0.5	0.4	0	49	50.7	0	142	146	0	28	28
2025	10	29	22	10	0	26.1	-1.8	0.944	0.5	0.5	0	49.5	51.2	0	143	147	0	28	28
2025	10	29	22	20	0	26.5	-1.4	0.944	0.4	0.3	0	49.5	51.2	0	142	147	0	27	28
2025	10	29	22	30	0	26.1	-1.1	0.944	0.4	0.3	0	49.5	51.2	0	142	147	0	27	28
2025	10	29	22	40	0	25.7	-2.6	0.944	0.5	0.4	0	49	51.6	0	142	147	0	28	27
2025	10	29	22	50	0	25.5	-0.9	0.944	0.5	0.5	0	49	51.2	0	142	147	0	28	28
2025	10	29	23	0	0	25.6	-0.9	0.944	0.5	0.4	0	49.5	51.2	0	142	147	0	27	28
2025	10	29	23	10	0	27.5	-2.2	0.944	0.4	0.3	0	49	51.2	0	141	147	0	27	28
2025	10	29	23	20	0	27.1	-1	0.944	0.5	0.4	0	48.6	50.7	0	141	146	0	28	28
2025	10	29	23	30	0	26.7	-0.6	0.943	0.5	0.4	0	48.2	51.2	0	141	147	0	29	28
2025	10	29	23	40	0	26.4	-1.6	0.943	0.4	0.3	0	48.6	51.2	0	141	147	0	28	28
2025	10	29	23	50	0	26.4	-1	0.943	0.5	0.4	0	48.6	51.2	0	141	147	0	28	28
2025	10	30	0	0	0	27	-0.4	0.943	0.5	0.5	0	49	51.2	0	141	147	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	30	0	10	0	27.4	-1.7	0.943	0.5	0.4	0	49	51.2	0	141	147	0	27	28
2025	10	30	0	20	0	26.8	-1.8	0.943	0.5	0.4	0	49	51.2	0	141	147	0	27	28
2025	10	30	0	30	0	25.9	-1	0.943	0.5	0.4	0	49	51.2	0	141	147	0	27	28
2025	10	30	0	40	0	26.7	-1.7	0.943	0.4	0.3	0	48.6	50.7	0	141	147	0	28	29
2025	10	30	0	50	0	25.9	-2.1	0.943	0.4	0.3	0	48.6	51.2	0	140	147	0	27	28
2025	10	30	1	0	0	25.4	-0.9	0.943	0.4	0.3	0	47.7	51.2	0	139	147	0	28	28
2025	10	30	1	10	0	26.4	-2	0.943	0.5	0.4	0	47.3	51.2	0	138	147	0	28	28
2025	10	30	1	20	0	26.4	-1	0.942	0.5	0.5	0	47.7	50.7	0	139	146	0	28	28
2025	10	30	1	30	0	27.4	-1.8	0.943	0.5	0.4	0	46.9	50.7	0	138	146	0	29	28
2025	10	30	1	40	0	27.1	-1.1	0.943	0.5	0.5	0	47.7	51.2	0	138	147	0	27	28
2025	10	30	1	50	0	27	-1.6	0.942	0.5	0.4	0	47.7	50.7	0	138	146	0	27	28
2025	10	30	2	0	0	25.6	-1.5	0.942	0.4	0.3	0	47.7	50.7	0	139	146	0	28	28
2025	10	30	2	10	0	26.1	-2.5	0.942	0.5	0.5	0	47.3	50.7	0	138	146	0	28	28
2025	10	30	2	20	0	26.6	-2.3	0.942	0.4	0.3	0	48.2	50.7	0	139	146	0	27	28
2025	10	30	2	30	0	26.4	-2.3	0.942	0.4	0.3	0	47.7	50.7	0	138	146	0	27	28
2025	10	30	2	40	0	26.3	-1.1	0.942	0.5	0.4	0	46.9	50.7	0	137	146	0	28	28
2025	10	30	2	50	0	26.5	-2.4	0.942	0.5	0.4	0	47.7	50.7	0	139	146	0	28	28
2025	10	30	3	0	0	26.7	-2	0.942	0.5	0.4	0	48.2	50.7	0	139	146	0	27	28
2025	10	30	3	10	0	26.8	-1.3	0.942	0.5	0.4	0	47.7	50.7	0	138	146	0	27	28
2025	10	30	3	20	0	26.9	-2.5	0.942	0.4	0.3	0	47.7	50.3	0	138	145	0	27	28
2025	10	30	3	30	0	25.8	-2.9	0.942	0.5	0.5	0	47.3	49.9	0	138	145	0	28	29
2025	10	30	3	40	0	25.8	-2.2	0.942	0.4	0.3	0	47.7	50.3	0	139	146	0	28	29
2025	10	30	3	50	0	25.5	-1.7	0.941	0.4	0.3	0	48.2	49.9	0	139	144	0	27	28
2025	10	30	4	0	0	26	-1.4	0.941	0.4	0.3	0	48.2	50.7	0	140	146	0	28	28
2025	10	30	4	10	0	26.8	-2.1	0.941	0.5	0.5	0	47.7	50.7	0	139	146	0	28	28
2025	10	30	4	20	0	27	-1.5	0.941	0.4	0.3	0	47.7	50.7	0	139	146	0	28	28
2025	10	30	4	30	0	26.8	-1.6	0.941	0.4	0.3	0	48.2	50.7	0	140	146	0	28	28
2025	10	30	4	40	0	27.1	-1.9	0.941	0.5	0.4	0	47.7	50.7	0	139	146	0	28	28
2025	10	30	4	50	0	26.5	-2.5	0.941	0.5	0.4	0	47.7	50.7	0	139	146	0	28	28
2025	10	30	5	0	0	26.1	-1.4	0.941	0.5	0.4	0	47.7	50.7	0	139	146	0	28	28
2025	10	30	5	10	0	25.4	-1	0.941	0.5	0.5	0	48.6	51.2	0	140	147	0	27	28
2025	10	30	5	20	0	26.5	-2	0.941	0.5	0.4	0	47.7	50.3	0	138	146	0	27	29
2025	10	30	5	30	0	26.9	-1.7	0.941	0.5	0.5	0	46.9	50.3	0	138	146	0	29	29
2025	10	30	5	40	0	26.4	-1.7	0.941	0.5	0.4	0	47.3	50.3	0	138	146	0	28	29
2025	10	30	5	50	0	27.3	-2.1	0.941	0.4	0.3	0	47.7	50.7	0	138	146	0	27	28
2025	10	30	6	0	0	26.8	-3.1	0.941	0.5	0.4	0	47.3	50.3	0	138	145	0	28	28
2025	10	30	6	10	0	26.5	-2.6	0.941	0.6	0.5	0	47.7	50.3	0	138	145	0	27	28
2025	10	30	6	20	0	26.9	-2.2	0.941	0.5	0.4	0	47.7	50.3	0	138	145	0	27	28
2025	10	30	6	30	0	26.1	-1.1	0.941	0.5	0.4	0	47.3	50.3	0	138	145	0	28	28
2025	10	30	6	40	0	25.9	-1.5	0.941	0.5	0.4	0	47.3	50.3	0	138	145	0	28	28
2025	10	30	6	50	0	26	-2.8	0.941	0.5	0.4	0	47.3	50.7	0	138	146	0	28	28
2025	10	30	7	0	0	26.3	-1.4	0.941	0.5	0.5	0	47.7	50.3	0	138	145	0	27	28
2025	10	30	7	10	0	26.8	-2.1	0.941	0.5	0.5	0	46.9	49.9	0	137	144	0	28	28
2025	10	30	7	20	0	26.6	-1.1	0.941	0.4	0.3	0	47.3	49.5	0	137	144	0	27	29
2025	10	30	7	30	0	27.2	-0.7	0.941	0.4	0.3	0	46.4	49.9	0	136	144	0	28	28
2025	10	30	7	40	0	26.7	-1.3	0.941	0.4	0.3	0	46.4	49.5	0	135	143	0	27	28
2025	10	30	7	50	0	27.5	-1.3	0.941	0.5	0.4	0	46.9	49	0	137	143	0	28	29
2025	10	30	8	0	0	26.2	-1.8	0.941	0.5	0.5	0	46.4	49	0	136	142	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	30	8	10	0	25.8	-2.4	0.941	0.5	0.4	0	46.9	49	0	137	142	0	28	28
2025	10	30	8	20	0	25.5	-2	0.941	0.5	0.5	0	46.4	49	0	135	142	0	27	28
2025	10	30	8	30	0	27.1	-2.5	0.941	0.5	0.4	0	47.3	48.6	0	137	141	0	27	28
2025	10	30	8	40	0	26.9	-1.6	0.941	0.5	0.4	0	46.4	48.6	0	136	141	0	28	28
2025	10	30	8	50	0	26.3	-1.1	0.941	0.5	0.4	0	46	47.7	0	135	140	0	28	29
2025	10	30	9	0	0	25.6	-0.6	0.941	0.5	0.4	0	46	47.7	0	135	140	0	28	29
2025	10	30	9	10	0	25.5	-3.4	0.941	0.4	0.3	0	45.2	47.7	0	134	139	0	29	28
2025	10	30	9	20	0	25.6	-1.4	0.941	0.4	0.3	0	46	46.9	0	134	138	0	27	29
2025	10	30	9	30	0	25.9	-2.4	0.941	0.5	0.4	0	45.6	47.3	0	134	138	0	28	28
2025	10	30	9	40	0	25.8	-2.1	0.941	0.5	0.5	0	44.3	47.3	0	131	137	0	28	27
2025	10	30	9	50	0	25.6	-1.2	0.941	0.5	0.5	0	45.2	46.9	0	132	137	0	27	28
2025	10	30	10	0	0	26.9	-2.1	0.941	0.4	0.3	0	44.3	46	0	131	136	0	28	29
2025	10	30	10	10	0	25.9	-1.5	0.941	0.4	0.3	0	44.3	46	0	131	135	0	28	28
2025	10	30	10	20	0	25.4	-0.7	0.941	0.6	0.5	0	43.9	46.4	0	131	136	0	29	28
2025	10	30	10	30	0	26.6	-2.5	0.941	0.4	0.3	0	44.7	46.4	0	132	136	0	28	28
2025	10	30	10	40	0	26	-2.1	0.941	0.5	0.4	0	44.7	46.4	0	132	136	0	28	28
2025	10	30	10	50	0	26.5	-2.1	0.941	0.4	0.3	0	45.2	46.4	0	132	136	0	27	28
2025	10	30	11	0	0	26.3	-1.3	0.941	0.3	0.2	0	44.7	46.4	0	132	136	0	28	28
2025	10	30	11	10	0	26	-1.4	0.941	0.5	0.4	0	44.3	46	0	131	135	0	28	28
2025	10	30	11	20	0	25.7	-1.6	0.941	0.4	0.3	0	44.7	46.4	0	132	136	0	28	28
2025	10	30	11	30	0	26.9	-1.7	0.941	0.3	0.2	0	44.7	46.4	0	132	136	0	28	28
2025	10	30	11	40	0	26.1	-1.3	0.941	0.5	0.4	0	44.7	46.4	0	132	136	0	28	28
2025	10	30	11	50	0	24.9	-2	0.941	0.5	0.4	0	45.2	46.4	0	132	136	0	27	28
2025	10	30	12	0	0	25.3	-2.2	0.941	0.4	0.3	0	45.2	46.4	0	132	136	0	27	28
2025	10	30	12	10	0	25.9	-3	0.941	0.5	0.4	0	44.7	46.4	0	132	136	0	28	28
2025	10	30	12	20	0	26.6	-1.7	0.941	0.5	0.4	0	44.3	46	0	131	135	0	28	28
2025	10	30	12	30	0	27.2	-3.2	0.942	0.4	0.3	0	44.7	46	0	131	135	0	27	28
2025	10	30	12	40	0	26.3	-2.5	0.942	0.5	0.4	0	44.3	46.9	0	131	136	0	28	27
2025	10	30	12	50	0	26.8	-2.6	0.942	0.4	0.3	0	45.2	46.4	0	132	136	0	27	28
2025	10	30	13	0	0	25.5	-2.5	0.942	0.5	0.4	0	44.3	46	0	131	135	0	28	28
2025	10	30	13	10	0	26.2	-1.6	0.942	0.5	0.5	0	44.7	46.9	0	132	137	0	28	28
2025	10	30	13	20	0	27.1	-1.2	0.942	0.4	0.3	0	45.2	46.4	0	132	136	0	27	28
2025	10	30	13	30	0	24.9	-2.1	0.942	0.4	0.3	0	45.2	46.4	0	132	136	0	27	28
2025	10	30	13	40	0	25.1	-1.9	0.942	0.5	0.4	0	44.7	46.4	0	132	135	0	28	27
2025	10	30	13	50	0	26	-1	0.942	0.5	0.5	0	44.7	46.9	0	132	136	0	28	27
2025	10	30	14	0	0	26.5	-2	0.942	0.5	0.4	0	45.2	46.9	0	132	136	0	27	27
2025	10	30	14	10	0	24.8	-2.1	0.942	0.5	0.4	0	45.2	46.4	0	132	136	0	27	28
2025	10	30	14	20	0	26.4	-2.7	0.942	0.5	0.5	0	45.2	47.3	0	133	138	0	28	28
2025	10	30	14	30	0	26.2	-2.9	0.943	0.5	0.4	0	45.6	46.9	0	133	137	0	27	28
2025	10	30	14	40	0	26.5	-1.8	0.943	0.4	0.3	0	45.2	46	0	132	136	0	27	29
2025	10	30	14	50	0	26.5	-1.7	0.943	0.5	0.5	0	45.2	46.4	0	132	136	0	27	28
2025	10	30	15	0	0	25.6	-1.9	0.943	0.3	0.2	0	45.2	46.9	0	133	137	0	28	28
2025	10	30	15	10	0	26.7	-1.5	0.943	0.5	0.4	0	45.6	46.9	0	133	137	0	27	28
2025	10	30	15	20	0	27.1	-2.5	0.943	0.4	0.3	0	45.2	46.9	0	132	136	0	27	27
2025	10	30	15	30	0	26.3	-1.7	0.943	0.5	0.4	0	45.2	47.3	0	132	137	0	27	27
2025	10	30	15	40	0	27	-1.5	0.943	0.3	0.2	0	45.6	47.3	0	133	138	0	27	28
2025	10	30	15	50	0	27	-1.8	0.943	0.5	0.5	0	46	47.7	0	134	138	0	27	27
2025	10	30	16	0	0	27.1	-1.7	0.943	0.5	0.5	0	46.4	47.7	0	135	139	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	30	16	10	0	26.4	-3.1	0.943	0.5	0.4	0	45.6	47.7	0	133	138	0	27	27
2025	10	30	16	20	0	26.5	-1.8	0.943	0.5	0.4	0	45.2	46.9	0	132	137	0	27	28
2025	10	30	16	30	0	26.6	-1.6	0.943	0.5	0.4	0	45.2	46.9	0	133	137	0	28	28
2025	10	30	16	40	0	27.1	-1.2	0.943	0.4	0.3	0	46	47.7	0	134	139	0	27	28
2025	10	30	16	50	0	26.6	-0.8	0.944	0.5	0.4	0	46.4	47.7	0	135	140	0	27	29
2025	10	30	17	0	0	25.4	-2.6	0.944	0.5	0.4	0	46	47.7	0	134	139	0	27	28
2025	10	30	17	10	0	28	-1.7	0.944	0.5	0.4	0	45.6	47.7	0	134	139	0	28	28
2025	10	30	17	20	0	27.1	-1.9	0.944	0.5	0.4	0	45.6	47.7	0	134	139	0	28	28
2025	10	30	17	30	0	26.6	-1.9	0.944	0.5	0.4	0	46.4	48.2	0	135	140	0	27	28
2025	10	30	17	40	0	26.9	-2.4	0.944	0.5	0.5	0	46.9	48.6	0	136	141	0	27	28
2025	10	30	17	50	0	27.5	-2.1	0.944	0.5	0.5	0	45.6	48.2	0	133	139	0	27	27
2025	10	30	18	0	0	27.8	-1.3	0.944	0.5	0.5	0	46	48.6	0	135	140	0	28	27
2025	10	30	18	10	0	26.3	-1.3	0.944	0.5	0.4	0	46.9	48.6	0	136	141	0	27	28
2025	10	30	18	20	0	27.8	-1	0.944	0.5	0.5	0	46.9	48.6	0	136	141	0	27	28
2025	10	30	18	30	0	27.4	-1.9	0.944	0.5	0.5	0	46.9	49.5	0	136	142	0	27	27
2025	10	30	18	40	0	27.1	-2.9	0.944	0.3	0.2	0	46.9	49	0	136	142	0	27	28
2025	10	30	18	50	0	26.5	-3	0.944	0.5	0.5	0	47.3	49	0	137	142	0	27	28
2025	10	30	19	0	0	25.7	-2.5	0.944	0.3	0.2	0	46.9	49.9	0	137	143	0	28	27
2025	10	30	19	10	0	27.4	-1.9	0.944	0.5	0.4	0	47.7	49.5	0	138	143	0	27	28
2025	10	30	19	20	0	27.2	-1.4	0.944	0.5	0.4	0	47.7	50.3	0	138	144	0	27	27
2025	10	30	19	30	0	27	-2.3	0.945	0.4	0.3	0	47.7	49.9	0	138	143	0	27	27
2025	10	30	19	40	0	26.7	-1.2	0.944	0.5	0.4	0	47.7	49.9	0	138	144	0	27	28
2025	10	30	19	50	0	26.7	-2.2	0.944	0.4	0.3	0	47.3	49.9	0	138	144	0	28	28
2025	10	30	20	0	0	27	-2.5	0.944	0.5	0.4	0	47.7	49.9	0	138	144	0	27	28
2025	10	30	20	10	0	26.8	-1.3	0.944	0.5	0.4	0	47.7	49.9	0	138	144	0	27	28
2025	10	30	20	20	0	26.3	-2	0.944	0.5	0.4	0	48.2	50.7	0	139	145	0	27	27
2025	10	30	20	30	0	25.8	-1.9	0.945	0.5	0.4	0	47.7	50.7	0	139	145	0	28	27
2025	10	30	20	40	0	26.5	-1.8	0.944	0.5	0.4	0	48.2	50.7	0	139	145	0	27	27
2025	10	30	20	50	0	27.5	-1.3	0.945	0.5	0.4	0	47.3	50.7	0	138	145	0	28	27
2025	10	30	21	0	0	25.7	-1.2	0.945	0.3	0.2	0	48.6	50.7	0	140	146	0	27	28
2025	10	30	21	10	0	25.9	-0.9	0.945	0.5	0.5	0	48.6	50.7	0	141	146	0	28	28
2025	10	30	21	20	0	26.2	-1.4	0.945	0.4	0.3	0	48.6	50.3	0	141	145	0	28	28
2025	10	30	21	30	0	27.9	-2.1	0.944	0.5	0.4	0	49	50.3	0	141	145	0	27	28
2025	10	30	21	40	0	26.7	-1.1	0.945	0.5	0.5	0	48.6	50.3	0	141	145	0	28	28
2025	10	30	21	50	0	26.9	-1.9	0.945	0.5	0.4	0	49	50.7	0	141	146	0	27	28
2025	10	30	22	0	0	27.4	-1.7	0.945	0.5	0.5	0	49	50.7	0	141	146	0	27	28
2025	10	30	22	10	0	27	-1.9	0.945	0.5	0.4	0	49	50.7	0	141	146	0	27	28
2025	10	30	22	20	0	26.9	-1.7	0.945	0.5	0.4	0	49.5	50.7	0	142	146	0	27	28
2025	10	30	22	30	0	26.3	-2	0.945	0.4	0.3	0	49	50.7	0	142	147	0	28	29
2025	10	30	22	40	0	26.5	-1.6	0.945	0.5	0.5	0	49.5	51.2	0	142	147	0	27	28
2025	10	30	22	50	0	26.8	-1.5	0.945	0.5	0.5	0	49	51.2	0	142	147	0	28	28
2025	10	30	23	0	0	27.9	-2.1	0.945	0.5	0.5	0	49.5	50.7	0	142	146	0	27	28
2025	10	30	23	10	0	26.6	-1	0.945	0.5	0.4	0	49	51.6	0	142	147	0	28	27
2025	10	30	23	20	0	26.2	-1.9	0.946	0.4	0.3	0	49	51.2	0	142	146	0	28	27
2025	10	30	23	30	0	26	-1.1	0.946	0.4	0.3	0	49	51.6	0	141	147	0	27	27
2025	10	30	23	40	0	27.5	-0.4	0.946	0.5	0.5	0	49.5	51.2	0	142	147	0	27	28
2025	10	30	23	50	0	25.9	-1.4	0.946	0.5	0.4	0	49	50.7	0	142	146	0	28	28
2025	10	31	0	0	0	26.8	-1.4	0.947	0.5	0.5	0	48.6	50.7	0	141	146	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	31	0	10	0	26.5	-1.9	0.946	0.3	0.2	0	48.6	50.7	0	141	146	0	28	28
2025	10	31	0	20	0	25.2	-1.4	0.947	0.4	0.3	0	49	51.2	0	142	147	0	28	28
2025	10	31	0	30	0	26.9	-1.8	0.947	0.5	0.4	0	48.6	50.7	0	141	146	0	28	28
2025	10	31	0	40	0	25.9	-1.8	0.947	0.5	0.5	0	48.6	50.3	0	141	146	0	28	29
2025	10	31	0	50	0	26.8	-2.2	0.947	0.4	0.3	0	48.6	50.7	0	141	146	0	28	28
2025	10	31	1	0	0	26.2	-1.8	0.947	0.5	0.5	0	48.6	51.2	0	141	146	0	28	27
2025	10	31	1	10	0	27.3	-3.5	0.947	0.4	0.3	0	49	50.7	0	141	146	0	27	28
2025	10	31	1	20	0	26.8	-2.1	0.947	0.4	0.3	0	48.2	50.7	0	140	146	0	28	28
2025	10	31	1	30	0	26.4	-1.8	0.947	0.4	0.3	0	48.2	50.7	0	140	146	0	28	28
2025	10	31	1	40	0	27	-2.1	0.947	0.6	0.5	0	48.2	50.3	0	140	145	0	28	28
2025	10	31	1	50	0	25.9	-0.9	0.947	0.4	0.3	0	48.6	51.2	0	140	146	0	27	27
2025	10	31	2	0	0	26.6	-2.8	0.947	0.4	0.3	0	48.2	50.7	0	140	146	0	28	28
2025	10	31	2	10	0	27	-1.8	0.947	0.4	0.3	0	48.2	50.7	0	140	146	0	28	28
2025	10	31	2	20	0	26.9	-2.1	0.947	0.5	0.5	0	48.2	50.3	0	139	145	0	27	28
2025	10	31	2	30	0	26.4	-3.3	0.947	0.5	0.4	0	48.2	50.3	0	139	145	0	27	28
2025	10	31	2	40	0	26.8	-0.6	0.947	0.5	0.4	0	48.6	50.3	0	140	145	0	27	28
2025	10	31	2	50	0	26.8	-1.3	0.947	0.5	0.4	0	48.2	50.3	0	140	145	0	28	28
2025	10	31	3	0	0	27.1	-3	0.947	0.5	0.5	0	47.7	49.9	0	139	144	0	28	28
2025	10	31	3	10	0	27.2	-2.1	0.947	0.5	0.5	0	47.7	50.3	0	139	145	0	28	28
2025	10	31	3	20	0	27.4	-1.4	0.947	0.4	0.3	0	48.2	50.3	0	140	145	0	28	28
2025	10	31	3	30	0	26.5	-1.9	0.947	0.4	0.3	0	47.7	50.3	0	139	145	0	28	28
2025	10	31	3	40	0	26.4	-2	0.947	0.5	0.5	0	48.6	49.9	0	140	145	0	27	29
2025	10	31	3	50	0	25.6	-2.5	0.947	0.5	0.4	0	47.7	50.3	0	139	145	0	28	28
2025	10	31	4	0	0	26.8	-2.1	0.947	0.5	0.4	0	47.7	50.3	0	139	145	0	28	28
2025	10	31	4	10	0	27.2	-2	0.947	0.5	0.4	0	46.9	49.9	0	137	145	0	28	29
2025	10	31	4	20	0	25.6	-1.7	0.947	0.4	0.3	0	46.9	50.7	0	137	145	0	28	27
2025	10	31	4	30	0	25.9	-2	0.947	0.6	0.5	0	47.7	49.9	0	138	145	0	27	29
2025	10	31	4	40	0	26.6	-0.6	0.947	0.5	0.4	0	47.3	50.3	0	138	145	0	28	28
2025	10	31	4	50	0	27.2	-1.2	0.947	0.5	0.4	0	46.9	49.9	0	137	144	0	28	28
2025	10	31	5	0	0	25.6	-1.3	0.947	0.5	0.5	0	47.3	49.9	0	138	144	0	28	28
2025	10	31	5	10	0	27.1	-2.2	0.947	0.3	0.2	0	47.3	50.3	0	138	145	0	28	28
2025	10	31	5	20	0	26.9	-2.3	0.947	0.3	0.2	0	46.9	49.5	0	137	144	0	28	29
2025	10	31	5	30	0	27.7	-2.1	0.947	0.4	0.3	0	47.7	50.3	0	138	145	0	27	28
2025	10	31	5	40	0	26.6	-1.7	0.947	0.4	0.3	0	46.9	49.9	0	137	144	0	28	28
2025	10	31	5	50	0	26.7	-2	0.947	0.5	0.4	0	47.7	50.3	0	138	145	0	27	28
2025	10	31	6	0	0	26	-2	0.947	0.5	0.4	0	47.3	49.9	0	137	144	0	27	28
2025	10	31	6	10	0	27	-3.1	0.947	0.5	0.4	0	47.3	50.3	0	138	145	0	28	28
2025	10	31	6	20	0	26.8	-1.1	0.947	0.5	0.5	0	47.3	49.5	0	137	144	0	27	29
2025	10	31	6	30	0	26	-0.9	0.947	0.4	0.3	0	46.9	50.3	0	137	145	0	28	28
2025	10	31	6	40	0	28.1	-2.1	0.947	0.5	0.4	0	46.9	49.9	0	137	145	0	28	29
2025	10	31	6	50	0	26.4	-2.5	0.947	0.4	0.3	0	46.9	49.9	0	137	144	0	28	28
2025	10	31	7	0	0	26.7	-2	0.947	0.5	0.4	0	46.9	50.3	0	137	145	0	28	28
2025	10	31	7	10	0	26.5	-2.3	0.947	0.4	0.3	0	46.9	50.3	0	137	145	0	28	28
2025	10	31	7	20	0	26.6	-2.4	0.947	0.3	0.2	0	46.9	50.3	0	137	145	0	28	28
2025	10	31	7	30	0	26.4	-1.4	0.947	0.5	0.5	0	46.4	49.9	0	136	144	0	28	28
2025	10	31	7	40	0	26.6	-2.1	0.947	0.5	0.4	0	46.9	49.9	0	136	144	0	27	28
2025	10	31	7	50	0	27.2	-1.6	0.947	0.4	0.3	0	46.4	49.5	0	136	143	0	28	28
2025	10	31	8	0	0	25.2	-2.2	0.947	0.5	0.4	0	46	49	0	135	142	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	31	8	10	0	27	-2.1	0.947	0.5	0.4	0	46.4	49	0	135	142	0	27	28
2025	10	31	8	20	0	26.5	-2.3	0.947	0.4	0.3	0	46	49	0	135	142	0	28	28
2025	10	31	8	30	0	26.7	-1.7	0.947	0.5	0.4	0	46	49	0	135	142	0	28	28
2025	10	31	8	40	0	27.7	-2.1	0.947	0.5	0.4	0	45.6	49	0	134	142	0	28	28
2025	10	31	8	50	0	26.6	-1.9	0.947	0.5	0.4	0	45.2	48.2	0	133	140	0	28	28
2025	10	31	9	0	0	26.9	-2.2	0.947	0.4	0.3	0	45.2	47.7	0	133	140	0	28	29
2025	10	31	9	10	0	26.8	-1.7	0.947	0.3	0.2	0	45.2	48.2	0	133	140	0	28	28
2025	10	31	9	20	0	26	-2.6	0.947	0.5	0.5	0	44.3	47.7	0	131	139	0	28	28
2025	10	31	9	30	0	26.9	-2.2	0.947	0.5	0.5	0	45.2	47.7	0	132	139	0	27	28
2025	10	31	9	40	0	27.2	-2.1	0.947	0.5	0.4	0	44.7	47.7	0	132	139	0	28	28
2025	10	31	9	50	0	26.8	-2.3	0.947	0.5	0.4	0	44.3	46.9	0	131	138	0	28	29
2025	10	31	10	0	0	25.7	-2.6	0.947	0.4	0.3	0	45.2	47.7	0	132	139	0	27	28
2025	10	31	10	10	0	25.7	-1.2	0.947	0.5	0.4	0	44.3	47.3	0	131	139	0	28	29
2025	10	31	10	20	0	26.2	-1.8	0.947	0.5	0.4	0	44.3	47.3	0	131	138	0	28	28
2025	10	31	10	30	0	27.2	-2.8	0.947	0.5	0.4	0	43.9	47.3	0	130	138	0	28	28
2025	10	31	10	40	0	27.1	-1.4	0.947	0.5	0.4	0	43.9	47.3	0	130	138	0	28	28
2025	10	31	10	50	0	26.5	-2.8	0.947	0.4	0.3	0	43.9	46.9	0	130	137	0	28	28
2025	10	31	11	0	0	27.7	-2.1	0.947	0.5	0.4	0	43.4	46.4	0	129	137	0	28	29
2025	10	31	11	10	0	25.7	-2.5	0.947	0.4	0.3	0	43	46.4	0	128	135	0	28	27
2025	10	31	11	20	0	25.7	-1.1	0.947	0.5	0.5	0	43.9	46.9	0	130	137	0	28	28
2025	10	31	11	30	0	27.2	-2.8	0.947	0.4	0.3	0	43	46	0	128	135	0	28	28
2025	10	31	11	40	0	26.5	-2.5	0.947	0.5	0.4	0	43	46.4	0	128	136	0	28	28
2025	10	31	11	50	0	26.3	-1.4	0.946	0.5	0.4	0	43.4	46	0	129	136	0	28	29
2025	10	31	12	0	0	26.3	-2.1	0.945	0.5	0.4	0	43.4	46.9	0	129	137	0	28	28
2025	10	31	12	10	0	25.1	-2.6	0.945	0.4	0.3	0	43.9	46.9	0	130	137	0	28	28
2025	10	31	12	20	0	26.3	-2.3	0.945	0.5	0.4	0	43.9	46.4	0	129	136	0	27	28
2025	10	31	12	30	0	26.3	-2.2	0.944	0.5	0.4	0	43.4	46	0	128	135	0	27	28
2025	10	31	12	40	0	26.9	-2.3	0.944	0.5	0.4	0	43.4	46	0	128	135	0	27	28
2025	10	31	12	50	0	26.1	-2	0.944	0.4	0.3	0	43.4	46.4	0	129	136	0	28	28
2025	10	31	13	0	0	26.7	-2.2	0.944	0.4	0.3	0	43.9	46.9	0	130	137	0	28	28
2025	10	31	13	10	0	25.9	-2.6	0.944	0.5	0.4	0	44.3	47.3	0	131	138	0	28	28
2025	10	31	13	20	0	25.6	-1.8	0.944	0.5	0.5	0	44.3	46.9	0	130	138	0	27	29
2025	10	31	13	30	0	26	-2.2	0.944	0.3	0.2	0	43.9	47.3	0	130	137	0	28	27
2025	10	31	13	40	0	26.9	-2.3	0.944	0.4	0.3	0	44.7	47.7	0	131	138	0	27	27
2025	10	31	13	50	0	25.3	-2.6	0.944	0.5	0.4	0	44.7	46.9	0	131	137	0	27	28
2025	10	31	14	0	0	26.4	-2.6	0.945	0.5	0.4	0	44.3	46.9	0	130	137	0	27	28
2025	10	31	14	10	0	25.2	-2.8	0.944	0.4	0.3	0	44.7	47.7	0	132	139	0	28	28
2025	10	31	14	20	0	26.6	-2.2	0.944	0.4	0.3	0	44.3	46.9	0	130	137	0	27	28
2025	10	31	14	30	0	26	-1.3	0.944	0.5	0.4	0	44.3	47.7	0	130	138	0	27	27
2025	10	31	14	40	0	26.2	-2.6	0.945	0.5	0.5	0	43.9	46.9	0	130	137	0	28	28
2025	10	31	14	50	0	25.9	-1.9	0.945	0.5	0.4	0	44.7	47.7	0	131	138	0	27	27
2025	10	31	15	0	0	27.9	-1.3	0.944	0.4	0.3	0	44.7	47.7	0	132	139	0	28	28
2025	10	31	15	10	0	25.8	-2.5	0.944	0.5	0.4	0	44.7	47.7	0	131	139	0	27	28
2025	10	31	15	20	0	26.9	-2.2	0.944	0.5	0.4	0	44.3	47.7	0	131	139	0	28	28
2025	10	31	15	30	0	26.3	-3	0.944	0.5	0.4	0	45.2	48.2	0	133	140	0	28	28
2025	10	31	15	40	0	26.6	-3.8	0.944	0.4	0.3	0	45.6	48.6	0	134	141	0	28	28
2025	10	31	15	50	0	26.3	-1.4	0.944	0.5	0.5	0	45.6	49	0	134	142	0	28	28
2025	10	31	16	0	0	26.4	-3.1	0.944	0.5	0.4	0	46	48.6	0	134	141	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	10	31	16	10	0	26.4	-1.6	0.945	0.5	0.4	0	45.2	48.6	0	133	141	0	28	28
2025	10	31	16	20	0	27	-2	0.945	0.5	0.4	0	45.2	48.2	0	132	140	0	27	28
2025	10	31	16	30	0	26.4	-1.6	0.945	0.4	0.3	0	45.2	48.6	0	132	140	0	27	27
2025	10	31	16	40	0	26.3	-2.1	0.945	0.5	0.4	0	45.6	48.6	0	133	141	0	27	28
2025	10	31	16	50	0	26.1	-2.6	0.945	0.5	0.4	0	46.4	49.9	0	135	143	0	27	27
2025	10	31	17	0	0	25.9	-2.2	0.945	0.4	0.3	0	46.4	49.9	0	135	144	0	27	28
2025	10	31	17	10	0	25.9	-0.9	0.945	0.4	0.3	0	45.6	49.5	0	134	142	0	28	27
2025	10	31	17	20	0	25.9	-2.2	0.945	0.5	0.4	0	45.6	49	0	133	142	0	27	28
2025	10	31	17	30	0	26.4	-1.9	0.945	0.5	0.4	0	45.2	49	0	133	142	0	28	28
2025	10	31	17	40	0	26.6	-2.9	0.945	0.5	0.4	0	45.2	49.5	0	132	142	0	27	27
2025	10	31	17	50	0	25.7	-1	0.945	0.5	0.4	0	45.2	49.5	0	133	143	0	28	28
2025	10	31	18	0	0	27.2	-1.3	0.945	0.5	0.4	0	44.7	48.6	0	131	141	0	27	28
2025	10	31	18	10	0	26.9	-2.1	0.945	0.4	0.3	0	44.7	49	0	131	141	0	27	27
2025	10	31	18	20	0	26.2	-1.2	0.945	0.5	0.4	0	44.7	49	0	132	142	0	28	28
2025	10	31	18	30	0	26.8	-2	0.945	0.4	0.3	0	44.3	49.5	0	131	142	0	28	27
2025	10	31	18	40	0	26.1	-0.1	0.945	0.4	0.3	0	45.2	49.5	0	132	142	0	27	27
2025	10	31	18	50	0	27.3	-1.3	0.945	0.5	0.4	0	45.2	48.6	0	132	141	0	27	28
2025	10	31	19	0	0	26.3	-1.7	0.945	0.5	0.5	0	45.2	49.5	0	133	143	0	28	28
2025	10	31	19	10	0	28.3	-2	0.945	0.5	0.4	0	45.2	49.5	0	133	142	0	28	27
2025	10	31	19	20	0	26.9	-1.7	0.945	0.5	0.4	0	46	49.9	0	134	144	0	27	28
2025	10	31	19	30	0	26.2	-1.5	0.945	0.5	0.4	0	46.4	49.9	0	135	144	0	27	28
2025	10	31	19	40	0	26.7	-1.9	0.945	0.5	0.5	0	46.4	50.7	0	135	145	0	27	27
2025	10	31	19	50	0	26.9	-1.6	0.945	0.4	0.3	0	46	50.7	0	135	145	0	28	27
2025	10	31	20	0	0	26.7	-1.2	0.945	0.5	0.4	0	46	49.9	0	134	144	0	27	28
2025	10	31	20	10	0	26.2	-2.8	0.945	0.5	0.4	0	45.6	49.9	0	134	144	0	28	28
2025	10	31	20	20	0	25.1	-3.2	0.945	0.5	0.4	0	46	49.9	0	134	144	0	27	28
2025	10	31	20	30	0	25.9	-2.4	0.945	0.4	0.3	0	46	49.9	0	135	144	0	28	28
2025	10	31	20	40	0	26.2	-1.4	0.944	0.5	0.5	0	45.6	50.3	0	134	145	0	28	28
2025	10	31	20	50	0	27.3	-1.7	0.944	0.5	0.4	0	46	49.9	0	134	144	0	27	28
2025	10	31	21	0	0	25.7	0	0.945	0.5	0.5	0	45.6	43.9	0	134	130	0	28	28
2025	10	31	21	10	0	27.8	-2.1	0.944	0.5	0.4	0	46.4	49.5	0	135	142	0	27	27
2025	10	31	21	20	0	25.9	-0.4	0.944	0.3	0.2	0	45.2	49.5	0	133	143	0	28	28
2025	10	31	21	30	0	26.9	-1.3	0.944	0.4	0.3	0	45.2	50.7	0	132	146	0	27	28
2025	10	31	21	40	0	25.9	-1.4	0.944	0.5	0.4	0	44.7	50.7	0	132	146	0	28	28
2025	10	31	21	50	0	26	-2.1	0.945	0.5	0.5	0	47.3	49.5	0	137	143	0	27	28
2025	10	31	22	0	0	26.1	-0.9	0.944	0.5	0.4	0	48.2	50.7	0	139	146	0	27	28
2025	10	31	22	10	0	26.5	-1.6	0.944	0.4	0.3	0	48.2	48.2	0	139	140	0	27	28
2025	10	31	22	20	0	27	-1.6	0.944	0.5	0.4	0	48.6	50.3	0	140	145	0	27	28
2025	10	31	22	30	0	25.9	-2.6	0.944	0.5	0.4	0	48.2	51.2	0	140	147	0	28	28
2025	10	31	22	40	0	26.4	-2.1	0.944	0.4	0.3	0	48.2	51.2	0	140	147	0	28	28
2025	10	31	22	50	0	26.1	-0.2	0.944	0.4	0.3	0	48.2	46.9	0	139	137	0	27	28
2025	10	31	23	0	0	26.6	-1.5	0.944	0.5	0.4	0	48.2	50.7	0	139	147	0	27	29
2025	10	31	23	10	0	24.7	-1.1	0.944	0.5	0.4	0	48.2	47.3	0	139	138	0	27	28
2025	10	31	23	20	0	26.2	-2.2	0.944	0.4	0.3	0	47.3	51.2	0	138	147	0	28	28
2025	10	31	23	30	0	26.5	-0.9	0.943	0.5	0.4	0	47.7	51.6	0	139	148	0	28	28
2025	10	31	23	40	0	25.5	-0.3	0.943	0.4	0.3	0	48.2	51.6	0	139	148	0	27	28
2025	10	31	23	50	0	27.6	-1.6	0.943	0.5	0.5	0	47.7	51.2	0	138	147	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	1	0	3	31	26	0	0	0	0	0	0	0	17.92	0	0
2025	10	1	0	13	31	26	0	0	0	0	0	0	0	17.88	0	0
2025	10	1	0	23	31	26	0	0	0	0	0	0	0	17.85	0	0
2025	10	1	0	33	31	25	0	0	0	0	0	0	0	17.81	0	0
2025	10	1	0	43	31	25	0	0	0	0	0	0	0	17.77	0	0
2025	10	1	0	53	31	26	0	0	0	0	0	0	0	17.74	0	0
2025	10	1	1	3	31	26	0	0	0	0	0	0	0	17.7	0	0
2025	10	1	1	13	31	25	0	0	0	0	0	0	0	17.66	0	0
2025	10	1	1	23	31	26	0	0	0	0	0	0	0	17.63	0	0
2025	10	1	1	33	31	26	0	0	0	0	0	0	0	17.59	0	0
2025	10	1	1	43	31	26	0	0	0	0	0	0	0	17.56	0	0
2025	10	1	1	53	31	26	0	0	0	0	0	0	0	17.53	0	0
2025	10	1	2	3	31	26	0	0	0	0	0	0	0	17.5	0	0
2025	10	1	2	13	31	26	0	0	0	0	0	0	0	17.47	0	0
2025	10	1	2	23	31	27	0	0	0	0	0	0	0	17.43	0	0
2025	10	1	2	33	31	26	0	0	0	0	0	0	0	17.4	0	0
2025	10	1	2	43	31	26	0	0	0	0	0	0	0	17.37	0	0
2025	10	1	2	53	31	26	0	0	0	0	0	0	0	17.33	0	0
2025	10	1	3	3	31	26	0	0	0	0	0	0	0	17.3	0	0
2025	10	1	3	13	31	26	0	0	0	0	0	0	0	17.27	0	0
2025	10	1	3	23	31	26	0	0	0	0	0	0	0	17.24	0	0
2025	10	1	3	33	31	26	0	0	0	0	0	0	0	17.21	0	0
2025	10	1	3	43	31	26	0	0	0	0	0	0	0	17.19	0	0
2025	10	1	3	53	31	26	0	0	0	0	0	0	0	17.16	0	0
2025	10	1	4	3	31	26	0	0	0	0	0	0	0	17.12	0	0
2025	10	1	4	13	31	26	0	0	0	0	0	0	0	17.09	0	0
2025	10	1	4	23	31	26	0	0	0	0	0	0	0	17.06	0	0
2025	10	1	4	33	31	26	0	0	0	0	0	0	0	17.03	0	0
2025	10	1	4	43	31	26	0	0	0	0	0	0	0	17	0	0
2025	10	1	4	53	31	26	0	0	0	0	0	0	0	16.97	0	0
2025	10	1	5	3	31	26	0	0	0	0	0	0	0	16.94	0	0
2025	10	1	5	13	31	26	0	0	0	0	0	0	0	16.91	0	0
2025	10	1	5	23	31	26	0	0	0	0	0	0	0	16.88	0	0
2025	10	1	5	33	31	26	0	0	0	0	0	0	0	16.85	0	0
2025	10	1	5	43	31	27	0	0	0	0	0	0	0	16.82	0	0
2025	10	1	5	53	31	25	0	0	0	0	0	0	0	16.79	0	0
2025	10	1	6	3	31	25	0	0	0	0	0	0	0	16.76	0	0
2025	10	1	6	13	31	26	0	0	0	0	0	0	0	16.72	0	0
2025	10	1	6	23	31	26	0	0	0	0	0	0	0	16.69	0	0
2025	10	1	6	33	31	26	0	0	0	0	0	0	0	16.66	0	0
2025	10	1	6	43	31	26	0	0	0	0	0	0	0	16.63	0	0
2025	10	1	6	53	31	26	0	0	0	0	0	0	0	16.6	0	0
2025	10	1	7	3	31	26	0	0	0	0	0	0	0	16.57	0	0
2025	10	1	7	13	31	26	0	0	0	0	0	0	0	16.54	0	0
2025	10	1	7	23	31	26	0	0	0	0	0	0	0	16.5	0	0
2025	10	1	7	33	31	26	0	0	0	0	0	0	0	16.47	0	0
2025	10	1	7	43	31	26	0	0	0	0	0	0	0	16.44	0	0
2025	10	1	7	53	31	27	0	0	0	0	0	0	0	16.41	0	0

Mazourka (0354)

	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	1	16	3	31	26	0	0	0	0	0	0	0	18.38	0	0
2025	10	1	16	13	31	25	0	0	0	0	0	0	0	18.4	0	0
2025	10	1	16	23	31	25	0	0	0	0	0	0	0	18.42	0	0
2025	10	1	16	33	31	26	0	0	0	0	0	0	0	18.44	0	0
2025	10	1	16	43	31	26	0	0	0	0	0	0	0	18.46	0	0
2025	10	1	16	53	31	26	0	0	0	0	0	0	0	18.47	0	0
2025	10	1	17	3	31	26	0	0	0	0	0	0	0	18.47	0	0
2025	10	1	17	13	31	26	0	0	0	0	0	0	0	18.47	0	0
2025	10	1	17	23	31	26	0	0	0	0	0	0	0	18.47	0	0
2025	10	1	17	33	31	25	0	0	0	0	0	0	0	18.47	0	0
2025	10	1	17	43	31	26	0	0	0	0	0	0	0	18.46	0	0
2025	10	1	17	53	31	26	0	0	0	0	0	0	0	18.45	0	0
2025	10	1	18	3	31	26	0	0	0	0	0	0	0	18.44	0	0
2025	10	1	18	13	31	26	0	0	0	0	0	0	0	18.42	0	0
2025	10	1	18	23	31	25	0	0	0	0	0	0	0	18.4	0	0
2025	10	1	18	33	31	26	0	0	0	0	0	0	0	18.38	0	0
2025	10	1	18	43	31	26	0	0	0	0	0	0	0	18.35	0	0
2025	10	1	18	53	31	26	0	0	0	0	0	0	0	18.33	0	0
2025	10	1	19	3	31	26	0	0	0	0	0	0	0	18.31	0	0
2025	10	1	19	13	31	26	0	0	0	0	0	0	0	18.29	0	0
2025	10	1	19	23	31	26	0	0	0	0	0	0	0	18.26	0	0
2025	10	1	19	33	31	26	0	0	0	0	0	0	0	18.23	0	0
2025	10	1	19	43	31	26	0	0	0	0	0	0	0	18.21	0	0
2025	10	1	19	53	31	26	0	0	0	0	0	0	0	18.18	0	0
2025	10	1	20	3	31	27	0	0	0	0	0	0	0	18.16	0	0
2025	10	1	20	13	31	25	0	0	0	0	0	0	0	18.13	0	0
2025	10	1	20	23	31	27	0	0	0	0	0	0	0	18.1	0	0
2025	10	1	20	33	31	26	0	0	0	0	0	0	0	18.07	0	0
2025	10	1	20	43	31	26	0	0	0	0	0	0	0	18.04	0	0
2025	10	1	20	53	31	26	0	0	0	0	0	0	0	18.02	0	0
2025	10	1	21	3	31	26	0	0	0	0	0	0	0	18	0	0
2025	10	1	21	13	31	26	0	0	0	0	0	0	0	17.97	0	0
2025	10	1	21	23	31	26	0	0	0	0	0	0	0	17.94	0	0
2025	10	1	21	33	31	26	0	0	0	0	0	0	0	17.91	0	0
2025	10	1	21	43	31	26	0	0	0	0	0	0	0	17.89	0	0
2025	10	1	21	53	31	26	0	0	0	0	0	0	0	17.86	0	0
2025	10	1	22	3	31	26	0	0	0	0	0	0	0	17.83	0	0
2025	10	1	22	13	31	25	0	0	0	0	0	0	0	17.81	0	0
2025	10	1	22	23	31	25	0	0	0	0	0	0	0	17.77	0	0
2025	10	1	22	33	31	26	0	0	0	0	0	0	0	17.75	0	0
2025	10	1	22	43	31	26	0	0	0	0	0	0	0	17.72	0	0
2025	10	1	22	53	31	26	0	0	0	0	0	0	0	17.69	0	0
2025	10	1	23	3	31	26	0	0	0	0	0	0	0	17.66	0	0
2025	10	1	23	13	31	26	0	0	0	0	0	0	0	17.63	0	0
2025	10	1	23	23	31	26	0	0	0	0	0	0	0	17.61	0	0
2025	10	1	23	33	31	25	0	0	0	0	0	0	0	17.58	0	0
2025	10	1	23	43	31	25	0	0	0	0	0	0	0	17.56	0	0
2025	10	1	23	53	31	26	0	0	0	0	0	0	0	17.53	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	2	0	3	31	27	0	0	0	0	0	0	0	17.5	0	0
2025	10	2	0	13	31	26	0	0	0	0	0	0	0	17.47	0	0
2025	10	2	0	23	31	26	0	0	0	0	0	0	0	17.44	0	0
2025	10	2	0	33	31	26	0	0	0	0	0	0	0	17.42	0	0
2025	10	2	0	43	31	27	0	0	0	0	0	0	0	17.39	0	0
2025	10	2	0	53	31	26	0	0	0	0	0	0	0	17.37	0	0
2025	10	2	1	3	31	25	0	0	0	0	0	0	0	17.34	0	0
2025	10	2	1	13	31	26	0	0	0	0	0	0	0	17.32	0	0
2025	10	2	1	23	31	26	0	0	0	0	0	0	0	17.3	0	0
2025	10	2	1	33	31	26	0	0	0	0	0	0	0	17.28	0	0
2025	10	2	1	43	31	26	0	0	0	0	0	0	0	17.25	0	0
2025	10	2	1	53	31	26	0	0	0	0	0	0	0	17.24	0	0
2025	10	2	2	3	31	26	0	0	0	0	0	0	0	17.21	0	0
2025	10	2	2	13	31	26	0	0	0	0	0	0	0	17.19	0	0
2025	10	2	2	23	31	26	0	0	0	0	0	0	0	17.17	0	0
2025	10	2	2	33	31	26	0	0	0	0	0	0	0	17.15	0	0
2025	10	2	2	43	31	26	0	0	0	0	0	0	0	17.12	0	0
2025	10	2	2	53	31	27	0	0	0	0	0	0	0	17.1	0	0
2025	10	2	3	3	31	25	0	0	0	0	0	0	0	17.08	0	0
2025	10	2	3	13	31	26	0	0	0	0	0	0	0	17.06	0	0
2025	10	2	3	23	31	26	0	0	0	0	0	0	0	17.04	0	0
2025	10	2	3	33	31	26	0	0	0	0	0	0	0	17.01	0	0
2025	10	2	3	43	31	26	0	0	0	0	0	0	0	17	0	0
2025	10	2	3	53	31	26	0	0	0	0	0	0	0	16.97	0	0
2025	10	2	4	3	31	27	0	0	0	0	0	0	0	16.95	0	0
2025	10	2	4	13	31	26	0	0	0	0	0	0	0	16.93	0	0
2025	10	2	4	23	31	26	0	0	0	0	0	0	0	16.9	0	0
2025	10	2	4	33	31	27	0	0	0	0	0	0	0	16.88	0	0
2025	10	2	4	43	31	26	0	0	0	0	0	0	0	16.85	0	0
2025	10	2	4	53	31	27	0	0	0	0	0	0	0	16.83	0	0
2025	10	2	5	3	31	26	0	0	0	0	0	0	0	16.8	0	0
2025	10	2	5	13	31	26	0	0	0	0	0	0	0	16.78	0	0
2025	10	2	5	23	31	26	0	0	0	0	0	0	0	16.76	0	0
2025	10	2	5	33	31	26	0	0	0	0	0	0	0	16.73	0	0
2025	10	2	5	43	31	26	0	0	0	0	0	0	0	16.71	0	0
2025	10	2	5	53	31	25	0	0	0	0	0	0	0	16.68	0	0
2025	10	2	6	3	31	26	0	0	0	0	0	0	0	16.66	0	0
2025	10	2	6	13	31	26	0	0	0	0	0	0	0	16.64	0	0
2025	10	2	6	23	31	25	0	0	0	0	0	0	0	16.61	0	0
2025	10	2	6	33	31	27	0	0	0	0	0	0	0	16.59	0	0
2025	10	2	6	43	31	27	0	0	0	0	0	0	0	16.56	0	0
2025	10	2	6	53	31	26	0	0	0	0	0	0	0	16.54	0	0
2025	10	2	7	3	31	26	0	0	0	0	0	0	0	16.52	0	0
2025	10	2	7	13	31	26	0	0	0	0	0	0	0	16.49	0	0
2025	10	2	7	23	31	26	0	0	0	0	0	0	0	16.46	0	0
2025	10	2	7	33	31	26	0	0	0	0	0	0	0	16.44	0	0
2025	10	2	7	43	31	26	0	0	0	0	0	0	0	16.42	0	0
2025	10	2	7	53	31	26	0	0	0	0	0	0	0	16.39	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

[illegible]

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	10	3	16	3	31	26	0	0	0	0	0	0	0	18.11	0	0
	2025	10	3	16	13	31	26	0	0	0	0	0	0	0	18.09	0	0
	2025	10	3	16	23	31	26	0	0	0	0	0	0	0	18.08	0	0
	2025	10	3	16	33	31	27	0	0	0	0	0	0	0	18.05	0	0
	2025	10	3	16	43	31	26	0	0	0	0	0	0	0	18.03	0	0
	2025	10	3	16	53	31	26	0	0	0	0	0	0	0	17.99	0	0
	2025	10	3	17	3	31	26	0	0	0	0	0	0	0	17.96	0	0
	2025	10	3	17	13	31	26	0	0	0	0	0	0	0	17.92	0	0
	2025	10	3	17	23	31	26	0	0	0	0	0	0	0	17.88	0	0
	2025	10	3	17	33	31	26	0	0	0	0	0	0	0	17.84	0	0
	2025	10	3	17	43	31	25	0	0	0	0	0	0	0	17.79	0	0
	2025	10	3	17	53	31	25	0	0	0	0	0	0	0	17.74	0	0
	2025	10	3	18	3	31	26	0	0	0	0	0	0	0	17.69	0	0
	2025	10	3	18	13	31	26	0	0	0	0	0	0	0	17.64	0	0
	2025	10	3	18	23	31	26	0	0	0	0	0	0	0	17.59	0	0
	2025	10	3	18	33	31	26	0	0	0	0	0	0	0	17.55	0	0
	2025	10	3	18	43	31	26	0	0	0	0	0	0	0	17.5	0	0
	2025	10	3	18	53	31	26	0	0	0	0	0	0	0	17.44	0	0
	2025	10	3	19	3	31	26	0	0	0	0	0	0	0	17.39	0	0
	2025	10	3	19	13	31	26	0	0	0	0	0	0	0	17.33	0	0
	2025	10	3	19	23	31	26	0	0	0	0	0	0	0	17.28	0	0
	2025	10	3	19	33	31	26	0	0	0	0	0	0	0	17.24	0	0
	2025	10	3	19	43	31	26	0	0	0	0	0	0	0	17.19	0	0
	2025	10	3	19	53	31	26	0	0	0	0	0	0	0	17.16	0	0
	2025	10	3	20	3	31	26	0	0	0	0	0	0	0	17.12	0	0
	2025	10	3	20	13	31	26	0	0	0	0	0	0	0	17.08	0	0
	2025	10	3	20	23	31	26	0	0	0	0	0	0	0	17.04	0	0
	2025	10	3	20	33	31	26	0	0	0	0	0	0	0	17	0	0
	2025	10	3	20	43	31	26	0	0	0	0	0	0	0	16.97	0	0
	2025	10	3	20	53	31	26	0	0	0	0	0	0	0	16.92	0	0
	2025	10	3	21	3	31	25	0	0	0	0	0	0	0	16.88	0	0
	2025	10	3	21	13	31	26	0	0	0	0	0	0	0	16.83	0	0
	2025	10	3	21	23	31	26	0	0	0	0	0	0	0	16.8	0	0
	2025	10	3	21	33	31	26	0	0	0	0	0	0	0	16.76	0	0
	2025	10	3	21	43	31	26	0	0	0	0	0	0	0	16.71	0	0
	2025	10	3	21	53	31	26	0	0	0	0	0	0	0	16.68	0	0
	2025	10	3	22	3	31	25	0	0	0	0	0	0	0	16.64	0	0
	2025	10	3	22	13	31	26	0	0	0	0	0	0	0	16.61	0	0
	2025	10	3	22	23	31	25	0	0	0	0	0	0	0	16.57	0	0
	2025	10	3	22	33	31	26	0	0	0	0	0	0	0	16.55	0	0
	2025	10	3	22	43	31	26	0	0	0	0	0	0	0	16.52	0	0
	2025	10	3	22	53	31	26	0	0	0	0	0	0	0	16.49	0	0
	2025	10	3	23	3	31	25	0	0	0	0	0	0	0	16.46	0	0
	2025	10	3	23	13	31	26	0	0	0	0	0	0	0	16.43	0	0
	2025	10	3	23	23	31	26	0	0	0	0	0	0	0	16.4	0	0
	2025	10	3	23	33	31	26	0	0	0	0	0	0	0	16.38	0	0
	2025	10	3	23	43	31	26	0	0	0	0	0	0	0	16.35	0	0
	2025	10	3	23	53	31	26	0	0	0	0	0	0	0	16.31	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

[illegible]

Mazourka (0354)

[illegible]

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	10	5	16	3	31	26	0	0	0	0	0	0	0	16.27	0	0
	2025	10	5	16	13	31	26	0	0	0	0	0	0	0	16.29	0	0
	2025	10	5	16	23	31	26	0	0	0	0	0	0	0	16.32	0	0
	2025	10	5	16	33	31	26	0	0	0	0	0	0	0	16.34	0	0
	2025	10	5	16	43	31	26	0	0	0	0	0	0	0	16.35	0	0
	2025	10	5	16	53	31	26	0	0	0	0	0	0	0	16.37	0	0
	2025	10	5	17	3	31	27	0	0	0	0	0	0	0	16.38	0	0
	2025	10	5	17	13	31	26	0	0	0	0	0	0	0	16.39	0	0
	2025	10	5	17	23	31	26	0	0	0	0	0	0	0	16.39	0	0
	2025	10	5	17	33	31	26	0	0	0	0	0	0	0	16.39	0	0
	2025	10	5	17	43	31	27	0	0	0	0	0	0	0	16.39	0	0
	2025	10	5	17	53	31	27	0	0	0	0	0	0	0	16.38	0	0
	2025	10	5	18	3	31	26	0	0	0	0	0	0	0	16.37	0	0
	2025	10	5	18	13	31	26	0	0	0	0	0	0	0	16.36	0	0
	2025	10	5	18	23	31	26	0	0	0	0	0	0	0	16.35	0	0
	2025	10	5	18	33	31	26	0	0	0	0	0	0	0	16.33	0	0
	2025	10	5	18	43	31	26	0	0	0	0	0	0	0	16.32	0	0
	2025	10	5	18	53	31	26	0	0	0	0	0	0	0	16.3	0	0
	2025	10	5	19	3	31	26	0	0	0	0	0	0	0	16.27	0	0
	2025	10	5	19	13	31	26	0	0	0	0	0	0	0	16.25	0	0
	2025	10	5	19	23	31	26	0	0	0	0	0	0	0	16.22	0	0
	2025	10	5	19	33	31	26	0	0	0	0	0	0	0	16.2	0	0
	2025	10	5	19	43	31	26	0	0	0	0	0	0	0	16.17	0	0
	2025	10	5	19	53	31	27	0	0	0	0	0	0	0	16.14	0	0
	2025	10	5	20	3	31	26	0	0	0	0	0	0	0	16.11	0	0
	2025	10	5	20	13	31	26	0	0	0	0	0	0	0	16.09	0	0
	2025	10	5	20	23	31	27	0	0	0	0	0	0	0	16.06	0	0
	2025	10	5	20	33	31	27	0	0	0	0	0	0	0	16.04	0	0
	2025	10	5	20	43	31	26	0	0	0	0	0	0	0	16.02	0	0
	2025	10	5	20	53	31	27	0	0	0	0	0	0	0	16	0	0
	2025	10	5	21	3	31	27	0	0	0	0	0	0	0	15.98	0	0
	2025	10	5	21	13	31	26	0	0	0	0	0	0	0	15.96	0	0
	2025	10	5	21	23	31	27	0	0	0	0	0	0	0	15.94	0	0
	2025	10	5	21	33	31	26	0	0	0	0	0	0	0	15.92	0	0
	2025	10	5	21	43	31	27	0	0	0	0	0	0	0	15.9	0	0
	2025	10	5	21	53	31	26	0	0	0	0	0	0	0	15.88	0	0
	2025	10	5	22	3	31	26	0	0	0	0	0	0	0	15.86	0	0
	2025	10	5	22	13	31	26	0	0	0	0	0	0	0	15.84	0	0
	2025	10	5	22	23	31	26	0	0	0	0	0	0	0	15.81	0	0
	2025	10	5	22	33	31	26	0	0	0	0	0	0	0	15.79	0	0
	2025	10	5	22	43	31	27	0	0	0	0	0	0	0	15.77	0	0
	2025	10	5	22	53	31	27	0	0	0	0	0	0	0	15.76	0	0
	2025	10	5	23	3	31	26	0	0	0	0	0	0	0	15.73	0	0
	2025	10	5	23	13	31	27	0	0	0	0	0	0	0	15.71	0	0
	2025	10	5	23	23	31	26	0	0	0	0	0	0	0	15.7	0	0
	2025	10	5	23	33	31	26	0	0	0	0	0	0	0	15.67	0	0
	2025	10	5	23	43	31	26	0	0	0	0	0	0	0	15.64	0	0
	2025	10	5	23	53	31	26	0	0	0	0	0	0	0	15.62	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	6	0	3	31	26	0	0	0	0	0	0	0	15.59	0	0
2025	10	6	0	13	31	27	0	0	0	0	0	0	0	15.57	0	0
2025	10	6	0	23	31	26	0	0	0	0	0	0	0	15.55	0	0
2025	10	6	0	33	31	27	0	0	0	0	0	0	0	15.52	0	0
2025	10	6	0	43	31	26	0	0	0	0	0	0	0	15.5	0	0
2025	10	6	0	53	31	26	0	0	0	0	0	0	0	15.48	0	0
2025	10	6	1	3	31	26	0	0	0	0	0	0	0	15.46	0	0
2025	10	6	1	13	31	26	0	0	0	0	0	0	0	15.44	0	0
2025	10	6	1	23	31	26	0	0	0	0	0	0	0	15.43	0	0
2025	10	6	1	33	31	26	0	0	0	0	0	0	0	15.41	0	0
2025	10	6	1	43	31	27	0	0	0	0	0	0	0	15.39	0	0
2025	10	6	1	53	31	27	0	0	0	0	0	0	0	15.37	0	0
2025	10	6	2	3	31	26	0	0	0	0	0	0	0	15.35	0	0
2025	10	6	2	13	31	25	0	0	0	0	0	0	0	15.33	0	0
2025	10	6	2	23	31	26	0	0	0	0	0	0	0	15.32	0	0
2025	10	6	2	33	31	26	0	0	0	0	0	0	0	15.3	0	0
2025	10	6	2	43	31	27	0	0	0	0	0	0	0	15.29	0	0
2025	10	6	2	53	31	27	0	0	0	0	0	0	0	15.27	0	0
2025	10	6	3	3	31	26	0	0	0	0	0	0	0	15.26	0	0
2025	10	6	3	13	31	27	0	0	0	0	0	0	0	15.24	0	0
2025	10	6	3	23	31	26	0	0	0	0	0	0	0	15.22	0	0
2025	10	6	3	33	31	27	0	0	0	0	0	0	0	15.21	0	0
2025	10	6	3	43	31	26	0	0	0	0	0	0	0	15.19	0	0
2025	10	6	3	53	31	26	0	0	0	0	0	0	0	15.17	0	0
2025	10	6	4	3	31	26	0	0	0	0	0	0	0	15.15	0	0
2025	10	6	4	13	31	26	0	0	0	0	0	0	0	15.13	0	0
2025	10	6	4	23	31	26	0	0	0	0	0	0	0	15.12	0	0
2025	10	6	4	33	31	26	0	0	0	0	0	0	0	15.1	0	0
2025	10	6	4	43	31	26	0	0	0	0	0	0	0	15.09	0	0
2025	10	6	4	53	31	26	0	0	0	0	0	0	0	15.07	0	0
2025	10	6	5	3	31	27	0	0	0	0	0	0	0	15.05	0	0
2025	10	6	5	13	31	27	0	0	0	0	0	0	0	15.04	0	0
2025	10	6	5	23	31	26	0	0	0	0	0	0	0	15.02	0	0
2025	10	6	5	33	31	26	0	0	0	0	0	0	0	15	0	0
2025	10	6	5	43	31	27	0	0	0	0	0	0	0	14.99	0	0
2025	10	6	5	53	31	27	0	0	0	0	0	0	0	14.97	0	0
2025	10	6	6	3	31	26	0	0	0	0	0	0	0	14.95	0	0
2025	10	6	6	13	31	26	0	0	0	0	0	0	0	14.93	0	0
2025	10	6	6	23	31	26	0	0	0	0	0	0	0	14.92	0	0
2025	10	6	6	33	31	26	0	0	0	0	0	0	0	14.9	0	0
2025	10	6	6	43	31	27	0	0	0	0	0	0	0	14.88	0	0
2025	10	6	6	53	31	27	0	0	0	0	0	0	0	14.86	0	0
2025	10	6	7	3	31	26	0	0	0	0	0	0	0	14.84	0	0
2025	10	6	7	13	31	26	0	0	0	0	0	0	0	14.82	0	0
2025	10	6	7	23	31	26	0	0	0	0	0	0	0	14.81	0	0
2025	10	6	7	33	31	26	0	0	0	0	0	0	0	14.79	0	0
2025	10	6	7	43	31	26	0	0	0	0	0	0	0	14.77	0	0
2025	10	6	7	53	31	26	0	0	0	0	0	0	0	14.76	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	7	0	3	31	27	0	0	0	0	0	0	0	15.72	0	0
2025	10	7	0	13	31	26	0	0	0	0	0	0	0	15.7	0	0
2025	10	7	0	23	31	26	0	0	0	0	0	0	0	15.67	0	0
2025	10	7	0	33	31	26	0	0	0	0	0	0	0	15.64	0	0
2025	10	7	0	43	31	26	0	0	0	0	0	0	0	15.62	0	0
2025	10	7	0	53	31	26	0	0	0	0	0	0	0	15.59	0	0
2025	10	7	1	3	31	26	0	0	0	0	0	0	0	15.56	0	0
2025	10	7	1	13	31	26	0	0	0	0	0	0	0	15.54	0	0
2025	10	7	1	23	31	26	0	0	0	0	0	0	0	15.51	0	0
2025	10	7	1	33	31	26	0	0	0	0	0	0	0	15.48	0	0
2025	10	7	1	43	31	27	0	0	0	0	0	0	0	15.46	0	0
2025	10	7	1	53	31	27	0	0	0	0	0	0	0	15.43	0	0
2025	10	7	2	3	31	27	0	0	0	0	0	0	0	15.41	0	0
2025	10	7	2	13	31	26	0	0	0	0	0	0	0	15.39	0	0
2025	10	7	2	23	31	26	0	0	0	0	0	0	0	15.37	0	0
2025	10	7	2	33	31	26	0	0	0	0	0	0	0	15.34	0	0
2025	10	7	2	43	31	26	0	0	0	0	0	0	0	15.31	0	0
2025	10	7	2	53	31	26	0	0	0	0	0	0	0	15.29	0	0
2025	10	7	3	3	31	26	0	0	0	0	0	0	0	15.27	0	0
2025	10	7	3	13	31	26	0	0	0	0	0	0	0	15.25	0	0
2025	10	7	3	23	31	27	0	0	0	0	0	0	0	15.22	0	0
2025	10	7	3	33	31	26	0	0	0	0	0	0	0	15.19	0	0
2025	10	7	3	43	31	26	0	0	0	0	0	0	0	15.17	0	0
2025	10	7	3	53	31	26	0	0	0	0	0	0	0	15.15	0	0
2025	10	7	4	3	31	27	0	0	0	0	0	0	0	15.13	0	0
2025	10	7	4	13	31	27	0	0	0	0	0	0	0	15.1	0	0
2025	10	7	4	23	31	26	0	0	0	0	0	0	0	15.08	0	0
2025	10	7	4	33	31	26	0	0	0	0	0	0	0	15.06	0	0
2025	10	7	4	43	31	27	0	0	0	0	0	0	0	15.04	0	0
2025	10	7	4	53	31	26	0	0	0	0	0	0	0	15.02	0	0
2025	10	7	5	3	31	26	0	0	0	0	0	0	0	15	0	0
2025	10	7	5	13	31	26	0	0	0	0	0	0	0	14.99	0	0
2025	10	7	5	23	31	26	0	0	0	0	0	0	0	14.97	0	0
2025	10	7	5	33	31	25	0	0	0	0	0	0	0	14.95	0	0
2025	10	7	5	43	31	26	0	0	0	0	0	0	0	14.93	0	0
2025	10	7	5	53	31	26	0	0	0	0	0	0	0	14.91	0	0
2025	10	7	6	3	31	27	0	0	0	0	0	0	0	14.89	0	0
2025	10	7	6	13	31	26	0	0	0	0	0	0	0	14.87	0	0
2025	10	7	6	23	31	26	0	0	0	0	0	0	0	14.85	0	0
2025	10	7	6	33	31	26	0	0	0	0	0	0	0	14.83	0	0
2025	10	7	6	43	31	26	0	0	0	0	0	0	0	14.81	0	0
2025	10	7	6	53	31	26	0	0	0	0	0	0	0	14.78	0	0
2025	10	7	7	3	31	26	0	0	0	0	0	0	0	14.77	0	0
2025	10	7	7	13	31	27	0	0	0	0	0	0	0	14.75	0	0
2025	10	7	7	23	31	26	0	0	0	0	0	0	0	14.73	0	0
2025	10	7	7	33	31	26	0	0	0	0	0	0	0	14.71	0	0
2025	10	7	7	43	31	27	0	0	0	0	0	0	0	14.7	0	0
2025	10	7	7	53	31	27	0	0	0	0	0	0	0	14.68	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	8	0	3	31	26	0	0	0	0	0	0	0	15.5	0	0
2025	10	8	0	13	31	27	0	0	0	0	0	0	0	15.47	0	0
2025	10	8	0	23	31	26	0	0	0	0	0	0	0	15.45	0	0
2025	10	8	0	33	31	26	0	0	0	0	0	0	0	15.42	0	0
2025	10	8	0	43	31	26	0	0	0	0	0	0	0	15.4	0	0
2025	10	8	0	53	31	26	0	0	0	0	0	0	0	15.37	0	0
2025	10	8	1	3	31	27	0	0	0	0	0	0	0	15.35	0	0
2025	10	8	1	13	31	26	0	0	0	0	0	0	0	15.31	0	0
2025	10	8	1	23	31	26	0	0	0	0	0	0	0	15.29	0	0
2025	10	8	1	33	31	26	0	0	0	0	0	0	0	15.27	0	0
2025	10	8	1	43	31	27	0	0	0	0	0	0	0	15.24	0	0
2025	10	8	1	53	31	27	0	0	0	0	0	0	0	15.22	0	0
2025	10	8	2	3	31	26	0	0	0	0	0	0	0	15.19	0	0
2025	10	8	2	13	31	27	0	0	0	0	0	0	0	15.17	0	0
2025	10	8	2	23	31	26	0	0	0	0	0	0	0	15.14	0	0
2025	10	8	2	33	31	27	0	0	0	0	0	0	0	15.12	0	0
2025	10	8	2	43	31	27	0	0	0	0	0	0	0	15.09	0	0
2025	10	8	2	53	31	26	0	0	0	0	0	0	0	15.07	0	0
2025	10	8	3	3	31	27	0	0	0	0	0	0	0	15.05	0	0
2025	10	8	3	13	31	27	0	0	0	0	0	0	0	15.02	0	0
2025	10	8	3	23	31	26	0	0	0	0	0	0	0	15	0	0
2025	10	8	3	33	31	26	0	0	0	0	0	0	0	14.98	0	0
2025	10	8	3	43	31	26	0	0	0	0	0	0	0	14.95	0	0
2025	10	8	3	53	31	26	0	0	0	0	0	0	0	14.92	0	0
2025	10	8	4	3	31	27	0	0	0	0	0	0	0	14.9	0	0
2025	10	8	4	13	31	27	0	0	0	0	0	0	0	14.88	0	0
2025	10	8	4	23	31	27	0	0	0	0	0	0	0	14.86	0	0
2025	10	8	4	33	31	27	0	0	0	0	0	0	0	14.83	0	0
2025	10	8	4	43	31	27	0	0	0	0	0	0	0	14.8	0	0
2025	10	8	4	53	31	26	0	0	0	0	0	0	0	14.77	0	0
2025	10	8	5	3	31	27	0	0	0	0	0	0	0	14.76	0	0
2025	10	8	5	13	31	26	0	0	0	0	0	0	0	14.73	0	0
2025	10	8	5	23	31	27	0	0	0	0	0	0	0	14.71	0	0
2025	10	8	5	33	31	27	0	0	0	0	0	0	0	14.68	0	0
2025	10	8	5	43	31	27	0	0	0	0	0	0	0	14.66	0	0
2025	10	8	5	53	31	26	0	0	0	0	0	0	0	14.63	0	0
2025	10	8	6	3	31	26	0	0	0	0	0	0	0	14.6	0	0
2025	10	8	6	13	31	26	0	0	0	0	0	0	0	14.58	0	0
2025	10	8	6	23	31	26	0	0	0	0	0	0	0	14.56	0	0
2025	10	8	6	33	31	26	0	0	0	0	0	0	0	14.52	0	0
2025	10	8	6	43	31	27	0	0	0	0	0	0	0	14.5	0	0
2025	10	8	6	53	31	27	0	0	0	0	0	0	0	14.46	0	0
2025	10	8	7	3	31	26	0	0	0	0	0	0	0	14.44	0	0
2025	10	8	7	13	31	26	0	0	0	0	0	0	0	14.4	0	0
2025	10	8	7	23	31	27	0	0	0	0	0	0	0	14.37	0	0
2025	10	8	7	33	31	27	0	0	0	0	0	0	0	14.34	0	0
2025	10	8	7	43	31	27	0	0	0	0	0	0	0	14.3	0	0
2025	10	8	7	53	31	26	0	0	0	0	0	0	0	14.28	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	9	16	3	31	26	0	0	0	0	0	0	0	15.96	0	0
2025	10	9	16	13	31	26	0	0	0	0	0	0	0	15.98	0	0
2025	10	9	16	23	31	27	0	0	0	0	0	0	0	15.98	0	0
2025	10	9	16	33	31	26	0	0	0	0	0	0	0	15.99	0	0
2025	10	9	16	43	31	26	0	0	0	0	0	0	0	16	0	0
2025	10	9	16	53	31	26	0	0	0	0	0	0	0	16	0	0
2025	10	9	17	3	31	27	0	0	0	0	0	0	0	15.99	0	0
2025	10	9	17	13	31	26	0	0	0	0	0	0	0	15.99	0	0
2025	10	9	17	23	31	26	0	0	0	0	0	0	0	15.98	0	0
2025	10	9	17	33	31	26	0	0	0	0	0	0	0	15.96	0	0
2025	10	9	17	43	31	26	0	0	0	0	0	0	0	15.95	0	0
2025	10	9	17	53	31	27	0	0	0	0	0	0	0	15.93	0	0
2025	10	9	18	3	31	27	0	0	0	0	0	0	0	15.9	0	0
2025	10	9	18	13	31	26	0	0	0	0	0	0	0	15.88	0	0
2025	10	9	18	23	31	26	0	0	0	0	0	0	0	15.86	0	0
2025	10	9	18	33	31	26	0	0	0	0	0	0	0	15.83	0	0
2025	10	9	18	43	31	27	0	0	0	0	0	0	0	15.81	0	0
2025	10	9	18	53	31	26	0	0	0	0	0	0	0	15.78	0	0
2025	10	9	19	3	31	26	0	0	0	0	0	0	0	15.76	0	0
2025	10	9	19	13	31	26	0	0	0	0	0	0	0	15.73	0	0
2025	10	9	19	23	31	26	0	0	0	0	0	0	0	15.7	0	0
2025	10	9	19	33	31	27	0	0	0	0	0	0	0	15.68	0	0
2025	10	9	19	43	31	26	0	0	0	0	0	0	0	15.65	0	0
2025	10	9	19	53	31	27	0	0	0	0	0	0	0	15.62	0	0
2025	10	9	20	3	31	27	0	0	0	0	0	0	0	15.6	0	0
2025	10	9	20	13	31	26	0	0	0	0	0	0	0	15.57	0	0
2025	10	9	20	23	31	26	0	0	0	0	0	0	0	15.55	0	0
2025	10	9	20	33	31	26	0	0	0	0	0	0	0	15.53	0	0
2025	10	9	20	43	31	26	0	0	0	0	0	0	0	15.5	0	0
2025	10	9	20	53	31	27	0	0	0	0	0	0	0	15.48	0	0
2025	10	9	21	3	31	26	0	0	0	0	0	0	0	15.46	0	0
2025	10	9	21	13	31	26	0	0	0	0	0	0	0	15.43	0	0
2025	10	9	21	23	31	26	0	0	0	0	0	0	0	15.41	0	0
2025	10	9	21	33	31	27	0	0	0	0	0	0	0	15.39	0	0
2025	10	9	21	43	31	26	0	0	0	0	0	0	0	15.37	0	0
2025	10	9	21	53	31	27	0	0	0	0	0	0	0	15.35	0	0
2025	10	9	22	3	31	27	0	0	0	0	0	0	0	15.33	0	0
2025	10	9	22	13	31	26	0	0	0	0	0	0	0	15.31	0	0
2025	10	9	22	23	31	27	0	0	0	0	0	0	0	15.29	0	0
2025	10	9	22	33	31	26	0	0	0	0	0	0	0	15.28	0	0
2025	10	9	22	43	31	27	0	0	0	0	0	0	0	15.26	0	0
2025	10	9	22	53	31	26	0	0	0	0	0	0	0	15.25	0	0
2025	10	9	23	3	31	26	0	0	0	0	0	0	0	15.23	0	0
2025	10	9	23	13	31	26	0	0	0	0	0	0	0	15.22	0	0
2025	10	9	23	23	31	26	0	0	0	0	0	0	0	15.21	0	0
2025	10	9	23	33	31	26	0	0	0	0	0	0	0	15.2	0	0
2025	10	9	23	43	31	26	0	0	0	0	0	0	0	15.2	0	0
2025	10	9	23	53	31	26	0	0	0	0	0	0	0	15.19	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	10	10	0	3	31	26	0	0	0	0	0	0	0	15.18	0	0
	2025	10	10	0	13	31	26	0	0	0	0	0	0	0	15.17	0	0
	2025	10	10	0	23	31	26	0	0	0	0	0	0	0	15.16	0	0
	2025	10	10	0	33	31	26	0	0	0	0	0	0	0	15.16	0	0
	2025	10	10	0	43	31	26	0	0	0	0	0	0	0	15.16	0	0
	2025	10	10	0	53	31	26	0	0	0	0	0	0	0	15.15	0	0
	2025	10	10	1	3	31	26	0	0	0	0	0	0	0	15.15	0	0
	2025	10	10	1	13	31	26	0	0	0	0	0	0	0	15.14	0	0
	2025	10	10	1	23	31	26	0	0	0	0	0	0	0	15.14	0	0
	2025	10	10	1	33	31	26	0	0	0	0	0	0	0	15.14	0	0
	2025	10	10	1	43	31	26	0	0	0	0	0	0	0	15.14	0	0
	2025	10	10	1	53	31	27	0	0	0	0	0	0	0	15.14	0	0
	2025	10	10	2	3	31	27	0	0	0	0	0	0	0	15.14	0	0
	2025	10	10	2	13	31	26	0	0	0	0	0	0	0	15.14	0	0
	2025	10	10	2	23	31	26	0	0	0	0	0	0	0	15.13	0	0
	2025	10	10	2	33	31	26	0	0	0	0	0	0	0	15.13	0	0
	2025	10	10	2	43	31	26	0	0	0	0	0	0	0	15.13	0	0
	2025	10	10	2	53	31	27	0	0	0	0	0	0	0	15.12	0	0
	2025	10	10	3	3	31	26	0	0	0	0	0	0	0	15.13	0	0
	2025	10	10	3	13	31	26	0	0	0	0	0	0	0	15.12	0	0
	2025	10	10	3	23	31	27	0	0	0	0	0	0	0	15.11	0	0
	2025	10	10	3	33	31	26	0	0	0	0	0	0	0	15.12	0	0
	2025	10	10	3	43	31	27	0	0	0	0	0	0	0	15.11	0	0
	2025	10	10	3	53	31	27	0	0	0	0	0	0	0	15.11	0	0
	2025	10	10	4	3	31	26	0	0	0	0	0	0	0	15.1	0	0
	2025	10	10	4	13	31	26	0	0	0	0	0	0	0	15.1	0	0
	2025	10	10	4	23	31	26	0	0	0	0	0	0	0	15.09	0	0
	2025	10	10	4	33	31	26	0	0	0	0	0	0	0	15.09	0	0
	2025	10	10	4	43	31	27	0	0	0	0	0	0	0	15.08	0	0
	2025	10	10	4	53	31	26	0	0	0	0	0	0	0	15.08	0	0
	2025	10	10	5	3	31	26	0	0	0	0	0	0	0	15.07	0	0
	2025	10	10	5	13	31	26	0	0	0	0	0	0	0	15.07	0	0
	2025	10	10	5	23	31	27	0	0	0	0	0	0	0	15.07	0	0
	2025	10	10	5	33	31	26	0	0	0	0	0	0	0	15.06	0	0
	2025	10	10	5	43	31	27	0	0	0	0	0	0	0	15.06	0	0
	2025	10	10	5	53	31	26	0	0	0	0	0	0	0	15.05	0	0
	2025	10	10	6	3	31	26	0	0	0	0	0	0	0	15.05	0	0
	2025	10	10	6	13	31	26	0	0	0	0	0	0	0	15.05	0	0
	2025	10	10	6	23	31	26	0	0	0	0	0	0	0	15.04	0	0
	2025	10	10	6	33	31	26	0	0	0	0	0	0	0	15.04	0	0
	2025	10	10	6	43	31	27	0	0	0	0	0	0	0	15.04	0	0
	2025	10	10	6	53	31	26	0	0	0	0	0	0	0	15.04	0	0
	2025	10	10	7	3	31	27	0	0	0	0	0	0	0	15.03	0	0
	2025	10	10	7	13	31	26	0	0	0	0	0	0	0	15.03	0	0
	2025	10	10	7	23	31	26	0	0	0	0	0	0	0	15.02	0	0
	2025	10	10	7	33	31	26	0	0	0	0	0	0	0	15.01	0	0
	2025	10	10	7	43	31	27	0	0	0	0	0	0	0	15.01	0	0
	2025	10	10	7	53	31	26	0	0	0	0	0	0	0	15.01	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	10	8	3	31	27	0	0	0	0	0	0	0	15	0	0
2025	10	10	8	13	31	27	0	0	0	0	0	0	0	15.01	0	0
2025	10	10	8	23	31	26	0	0	0	0	0	0	0	15	0	0
2025	10	10	8	33	31	26	0	0	0	0	0	0	0	15.01	0	0
2025	10	10	8	43	31	27	0	0	0	0	0	0	0	15.01	0	0
2025	10	10	8	53	31	26	0	0	0	0	0	0	0	15.02	0	0
2025	10	10	9	3	31	26	0	0	0	0	0	0	0	15.03	0	0
2025	10	10	9	13	31	26	0	0	0	0	0	0	0	15.04	0	0
2025	10	10	9	23	31	26	0	0	0	0	0	0	0	15.07	0	0
2025	10	10	9	33	31	26	0	0	0	0	0	0	0	15.09	0	0
2025	10	10	9	43	31	26	0	0	0	0	0	0	0	15.12	0	0
2025	10	10	9	53	31	27	0	0	0	0	0	0	0	15.15	0	0
2025	10	10	10	3	31	26	0	0	0	0	0	0	0	15.18	0	0
2025	10	10	10	13	31	27	0	0	0	0	0	0	0	15.22	0	0
2025	10	10	10	23	31	26	0	0	0	0	0	0	0	15.26	0	0
2025	10	10	10	33	31	27	0	0	0	0	0	0	0	15.3	0	0
2025	10	10	10	43	31	26	0	0	0	0	0	0	0	15.35	0	0
2025	10	10	10	53	31	26	0	0	0	0	0	0	0	15.4	0	0
2025	10	10	11	3	31	27	0	0	0	0	0	0	0	15.45	0	0
2025	10	10	11	13	31	26	0	0	0	0	0	0	0	15.51	0	0
2025	10	10	11	23	31	27	0	0	0	0	0	0	0	15.57	0	0
2025	10	10	11	33	31	26	0	0	0	0	0	0	0	15.62	0	0
2025	10	10	11	43	31	26	0	0	0	0	0	0	0	15.69	0	0
2025	10	10	11	53	31	27	0	0	0	0	0	0	0	15.75	0	0
2025	10	10	12	3	31	26	0	0	0	0	0	0	0	15.81	0	0
2025	10	10	12	13	31	26	0	0	0	0	0	0	0	15.88	0	0
2025	10	10	12	23	31	26	0	0	0	0	0	0	0	15.94	0	0
2025	10	10	12	33	31	26	0	0	0	0	0	0	0	16.01	0	0
2025	10	10	12	43	31	27	0	0	0	0	0	0	0	16.07	0	0
2025	10	10	12	53	31	26	0	0	0	0	0	0	0	16.14	0	0
2025	10	10	13	3	31	26	0	0	0	0	0	0	0	16.2	0	0
2025	10	10	13	13	31	26	0	0	0	0	0	0	0	16.27	0	0
2025	10	10	13	23	31	27	0	0	0	0	0	0	0	16.33	0	0
2025	10	10	13	33	31	26	0	0	0	0	0	0	0	16.39	0	0
2025	10	10	13	43	31	27	0	0	0	0	0	0	0	16.45	0	0
2025	10	10	13	53	31	26	0	0	0	0	0	0	0	16.51	0	0
2025	10	10	14	3	31	26	0	0	0	0	0	0	0	16.57	0	0
2025	10	10	14	13	31	26	0	0	0	0	0	0	0	16.63	0	0
2025	10	10	14	23	31	26	0	0	0	0	0	0	0	16.68	0	0
2025	10	10	14	33	31	26	0	0	0	0	0	0	0	16.74	0	0
2025	10	10	14	43	31	26	0	0	0	0	0	0	0	16.79	0	0
2025	10	10	14	53	31	26	0	0	0	0	0	0	0	16.83	0	0
2025	10	10	15	3	31	26	0	0	0	0	0	0	0	16.88	0	0
2025	10	10	15	13	31	26	0	0	0	0	0	0	0	16.92	0	0
2025	10	10	15	23	31	26	0	0	0	0	0	0	0	16.96	0	0
2025	10	10	15	33	31	26	0	0	0	0	0	0	0	16.99	0	0
2025	10	10	15	43	31	26	0	0	0	0	0	0	0	17.03	0	0
2025	10	10	15	53	31	26	0	0	0	0	0	0	0	17.05	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	10	16	3	31	26	0	0	0	0	0	0	0	17.08	0	0
2025	10	10	16	13	31	26	0	0	0	0	0	0	0	17.1	0	0
2025	10	10	16	23	31	27	0	0	0	0	0	0	0	17.12	0	0
2025	10	10	16	33	31	26	0	0	0	0	0	0	0	17.13	0	0
2025	10	10	16	43	31	26	0	0	0	0	0	0	0	17.14	0	0
2025	10	10	16	53	31	26	0	0	0	0	0	0	0	17.15	0	0
2025	10	10	17	3	31	26	0	0	0	0	0	0	0	17.15	0	0
2025	10	10	17	13	31	26	0	0	0	0	0	0	0	17.15	0	0
2025	10	10	17	23	31	27	0	0	0	0	0	0	0	17.15	0	0
2025	10	10	17	33	31	27	0	0	0	0	0	0	0	17.14	0	0
2025	10	10	17	43	31	27	0	0	0	0	0	0	0	17.13	0	0
2025	10	10	17	53	31	26	0	0	0	0	0	0	0	17.1	0	0
2025	10	10	18	3	31	26	0	0	0	0	0	0	0	17.08	0	0
2025	10	10	18	13	31	26	0	0	0	0	0	0	0	17.06	0	0
2025	10	10	18	23	31	26	0	0	0	0	0	0	0	17.04	0	0
2025	10	10	18	33	31	26	0	0	0	0	0	0	0	17.01	0	0
2025	10	10	18	43	31	26	0	0	0	0	0	0	0	16.98	0	0
2025	10	10	18	53	31	26	0	0	0	0	0	0	0	16.95	0	0
2025	10	10	19	3	31	26	0	0	0	0	0	0	0	16.91	0	0
2025	10	10	19	13	31	26	0	0	0	0	0	0	0	16.87	0	0
2025	10	10	19	23	31	27	0	0	0	0	0	0	0	16.85	0	0
2025	10	10	19	33	31	26	0	0	0	0	0	0	0	16.8	0	0
2025	10	10	19	43	31	26	0	0	0	0	0	0	0	16.77	0	0
2025	10	10	19	53	31	26	0	0	0	0	0	0	0	16.73	0	0
2025	10	10	20	3	31	25	0	0	0	0	0	0	0	16.69	0	0
2025	10	10	20	13	31	27	0	0	0	0	0	0	0	16.65	0	0
2025	10	10	20	23	31	26	0	0	0	0	0	0	0	16.61	0	0
2025	10	10	20	33	31	26	0	0	0	0	0	0	0	16.57	0	0
2025	10	10	20	43	31	26	0	0	0	0	0	0	0	16.53	0	0
2025	10	10	20	53	31	26	0	0	0	0	0	0	0	16.49	0	0
2025	10	10	21	3	31	26	0	0	0	0	0	0	0	16.45	0	0
2025	10	10	21	13	31	26	0	0	0	0	0	0	0	16.42	0	0
2025	10	10	21	23	31	27	0	0	0	0	0	0	0	16.39	0	0
2025	10	10	21	33	31	27	0	0	0	0	0	0	0	16.36	0	0
2025	10	10	21	43	31	26	0	0	0	0	0	0	0	16.33	0	0
2025	10	10	21	53	31	26	0	0	0	0	0	0	0	16.3	0	0
2025	10	10	22	3	31	26	0	0	0	0	0	0	0	16.27	0	0
2025	10	10	22	13	31	26	0	0	0	0	0	0	0	16.24	0	0
2025	10	10	22	23	31	26	0	0	0	0	0	0	0	16.21	0	0
2025	10	10	22	33	31	26	0	0	0	0	0	0	0	16.19	0	0
2025	10	10	22	43	31	26	0	0	0	0	0	0	0	16.16	0	0
2025	10	10	22	53	31	27	0	0	0	0	0	0	0	16.14	0	0
2025	10	10	23	3	31	27	0	0	0	0	0	0	0	16.12	0	0
2025	10	10	23	13	31	26	0	0	0	0	0	0	0	16.1	0	0
2025	10	10	23	23	31	26	0	0	0	0	0	0	0	16.07	0	0
2025	10	10	23	33	31	25	0	0	0	0	0	0	0	16.05	0	0
2025	10	10	23	43	31	26	0	0	0	0	0	0	0	16.03	0	0
2025	10	10	23	53	31	26	0	0	0	0	0	0	0	16	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	10	11	0	3	31	26	0	0	0	0	0	0	0	15.98	0	0
	2025	10	11	0	13	31	26	0	0	0	0	0	0	0	15.96	0	0
	2025	10	11	0	23	31	26	0	0	0	0	0	0	0	15.93	0	0
	2025	10	11	0	33	31	26	0	0	0	0	0	0	0	15.91	0	0
	2025	10	11	0	43	31	26	0	0	0	0	0	0	0	15.9	0	0
	2025	10	11	0	53	31	27	0	0	0	0	0	0	0	15.87	0	0
	2025	10	11	1	3	31	26	0	0	0	0	0	0	0	15.85	0	0
	2025	10	11	1	13	31	26	0	0	0	0	0	0	0	15.83	0	0
	2025	10	11	1	23	31	26	0	0	0	0	0	0	0	15.82	0	0
	2025	10	11	1	33	31	26	0	0	0	0	0	0	0	15.81	0	0
	2025	10	11	1	43	31	26	0	0	0	0	0	0	0	15.79	0	0
	2025	10	11	1	53	31	26	0	0	0	0	0	0	0	15.77	0	0
	2025	10	11	2	3	31	25	0	0	0	0	0	0	0	15.76	0	0
	2025	10	11	2	13	31	26	0	0	0	0	0	0	0	15.74	0	0
	2025	10	11	2	23	31	26	0	0	0	0	0	0	0	15.73	0	0
	2025	10	11	2	33	31	27	0	0	0	0	0	0	0	15.72	0	0
	2025	10	11	2	43	31	26	0	0	0	0	0	0	0	15.7	0	0
	2025	10	11	2	53	31	26	0	0	0	0	0	0	0	15.69	0	0
	2025	10	11	3	3	31	26	0	0	0	0	0	0	0	15.66	0	0
	2025	10	11	3	13	31	26	0	0	0	0	0	0	0	15.65	0	0
	2025	10	11	3	23	31	26	0	0	0	0	0	0	0	15.63	0	0
	2025	10	11	3	33	31	26	0	0	0	0	0	0	0	15.61	0	0
	2025	10	11	3	43	31	26	0	0	0	0	0	0	0	15.59	0	0
	2025	10	11	3	53	31	26	0	0	0	0	0	0	0	15.57	0	0
	2025	10	11	4	3	31	26	0	0	0	0	0	0	0	15.54	0	0
	2025	10	11	4	13	31	26	0	0	0	0	0	0	0	15.52	0	0
	2025	10	11	4	23	31	26	0	0	0	0	0	0	0	15.5	0	0
	2025	10	11	4	33	31	26	0	0	0	0	0	0	0	15.46	0	0
	2025	10	11	4	43	31	27	0	0	0	0	0	0	0	15.44	0	0
	2025	10	11	4	53	31	26	0	0	0	0	0	0	0	15.4	0	0
	2025	10	11	5	3	31	27	0	0	0	0	0	0	0	15.37	0	0
	2025	10	11	5	13	31	26	0	0	0	0	0	0	0	15.34	0	0
	2025	10	11	5	23	31	26	0	0	0	0	0	0	0	15.3	0	0
	2025	10	11	5	33	31	26	0	0	0	0	0	0	0	15.27	0	0
	2025	10	11	5	43	31	27	0	0	0	0	0	0	0	15.24	0	0
	2025	10	11	5	53	31	26	0	0	0	0	0	0	0	15.2	0	0
	2025	10	11	6	3	31	26	0	0	0	0	0	0	0	15.16	0	0
	2025	10	11	6	13	31	26	0	0	0	0	0	0	0	15.13	0	0
	2025	10	11	6	23	31	26	0	0	0	0	0	0	0	15.08	0	0
	2025	10	11	6	33	31	26	0	0	0	0	0	0	0	15.05	0	0
	2025	10	11	6	43	31	27	0	0	0	0	0	0	0	15.01	0	0
	2025	10	11	6	53	31	26	0	0	0	0	0	0	0	14.98	0	0
	2025	10	11	7	3	31	27	0	0	0	0	0	0	0	14.95	0	0
	2025	10	11	7	13	31	26	0	0	0	0	0	0	0	14.91	0	0
	2025	10	11	7	23	31	26	0	0	0	0	0	0	0	14.88	0	0
	2025	10	11	7	33	31	27	0	0	0	0	0	0	0	14.85	0	0
	2025	10	11	7	43	31	27	0	0	0	0	0	0	0	14.82	0	0
	2025	10	11	7	53	31	26	0	0	0	0	0	0	0	14.79	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	11	8	3	31	27	0	0	0	0	0	0	0	14.76	0	0
2025	10	11	8	13	31	26	0	0	0	0	0	0	0	14.73	0	0
2025	10	11	8	23	31	27	0	0	0	0	0	0	0	14.71	0	0
2025	10	11	8	33	31	26	0	0	0	0	0	0	0	14.7	0	0
2025	10	11	8	43	31	27	0	0	0	0	0	0	0	14.68	0	0
2025	10	11	8	53	31	26	0	0	0	0	0	0	0	14.67	0	0
2025	10	11	9	3	31	27	0	0	0	0	0	0	0	14.68	0	0
2025	10	11	9	13	31	26	0	0	0	0	0	0	0	14.68	0	0
2025	10	11	9	23	31	26	0	0	0	0	0	0	0	14.69	0	0
2025	10	11	9	33	31	27	0	0	0	0	0	0	0	14.71	0	0
2025	10	11	9	43	31	26	0	0	0	0	0	0	0	14.72	0	0
2025	10	11	9	53	31	26	0	0	0	0	0	0	0	14.75	0	0
2025	10	11	10	3	31	26	0	0	0	0	0	0	0	14.77	0	0
2025	10	11	10	13	31	27	0	0	0	0	0	0	0	14.81	0	0
2025	10	11	10	23	31	26	0	0	0	0	0	0	0	14.85	0	0
2025	10	11	10	33	31	26	0	0	0	0	0	0	0	14.88	0	0
2025	10	11	10	43	31	26	0	0	0	0	0	0	0	14.92	0	0
2025	10	11	10	53	31	27	0	0	0	0	0	0	0	14.96	0	0
2025	10	11	11	3	31	26	0	0	0	0	0	0	0	15.01	0	0
2025	10	11	11	13	31	27	0	0	0	0	0	0	0	15.06	0	0
2025	10	11	11	23	31	27	0	0	0	0	0	0	0	15.11	0	0
2025	10	11	11	33	31	27	0	0	0	0	0	0	0	15.16	0	0
2025	10	11	11	43	31	26	0	0	0	0	0	0	0	15.22	0	0
2025	10	11	11	53	31	26	0	0	0	0	0	0	0	15.26	0	0
2025	10	11	12	3	31	26	0	0	0	0	0	0	0	15.31	0	0
2025	10	11	12	13	31	26	0	0	0	0	0	0	0	15.36	0	0
2025	10	11	12	23	31	26	0	0	0	0	0	0	0	15.43	0	0
2025	10	11	12	33	31	27	0	0	0	0	0	0	0	15.47	0	0
2025	10	11	12	43	31	26	0	0	0	0	0	0	0	15.53	0	0
2025	10	11	12	53	31	27	0	0	0	0	0	0	0	15.57	0	0
2025	10	11	13	3	31	26	0	0	0	0	0	0	0	15.62	0	0
2025	10	11	13	13	31	27	0	0	0	0	0	0	0	15.66	0	0
2025	10	11	13	23	31	26	0	0	0	0	0	0	0	15.67	0	0
2025	10	11	13	33	31	26	0	0	0	0	0	0	0	15.69	0	0
2025	10	11	13	43	31	26	0	0	0	0	0	0	0	15.72	0	0
2025	10	11	13	53	31	26	0	0	0	0	0	0	0	15.75	0	0
2025	10	11	14	3	31	26	0	0	0	0	0	0	0	15.79	0	0
2025	10	11	14	13	31	26	0	0	0	0	0	0	0	15.83	0	0
2025	10	11	14	23	31	27	0	0	0	0	0	0	0	15.87	0	0
2025	10	11	14	33	31	26	0	0	0	0	0	0	0	15.9	0	0
2025	10	11	14	43	31	26	0	0	0	0	0	0	0	15.93	0	0
2025	10	11	14	53	31	26	0	0	0	0	0	0	0	15.96	0	0
2025	10	11	15	3	31	26	0	0	0	0	0	0	0	15.99	0	0
2025	10	11	15	13	31	27	0	0	0	0	0	0	0	16.01	0	0
2025	10	11	15	23	31	27	0	0	0	0	0	0	0	16.04	0	0
2025	10	11	15	33	31	26	0	0	0	0	0	0	0	16.05	0	0
2025	10	11	15	43	31	27	0	0	0	0	0	0	0	16.07	0	0
2025	10	11	15	53	31	27	0	0	0	0	0	0	0	16.07	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	11	16	3	31	27	0	0	0	0	0	0	0	16.08	0	0
2025	10	11	16	13	31	26	0	0	0	0	0	0	0	16.07	0	0
2025	10	11	16	23	31	26	0	0	0	0	0	0	0	16.08	0	0
2025	10	11	16	33	31	27	0	0	0	0	0	0	0	16.08	0	0
2025	10	11	16	43	31	26	0	0	0	0	0	0	0	16.08	0	0
2025	10	11	16	53	31	26	0	0	0	0	0	0	0	16.07	0	0
2025	10	11	17	3	31	26	0	0	0	0	0	0	0	16.05	0	0
2025	10	11	17	13	31	26	0	0	0	0	0	0	0	16.04	0	0
2025	10	11	17	23	31	26	0	0	0	0	0	0	0	16.01	0	0
2025	10	11	17	33	31	26	0	0	0	0	0	0	0	15.98	0	0
2025	10	11	17	43	31	26	0	0	0	0	0	0	0	15.95	0	0
2025	10	11	17	53	31	26	0	0	0	0	0	0	0	15.92	0	0
2025	10	11	18	3	31	26	0	0	0	0	0	0	0	15.88	0	0
2025	10	11	18	13	31	26	0	0	0	0	0	0	0	15.85	0	0
2025	10	11	18	23	31	27	0	0	0	0	0	0	0	15.8	0	0
2025	10	11	18	33	31	26	0	0	0	0	0	0	0	15.77	0	0
2025	10	11	18	43	31	27	0	0	0	0	0	0	0	15.73	0	0
2025	10	11	18	53	31	26	0	0	0	0	0	0	0	15.69	0	0
2025	10	11	19	3	31	27	0	0	0	0	0	0	0	15.65	0	0
2025	10	11	19	13	31	26	0	0	0	0	0	0	0	15.61	0	0
2025	10	11	19	23	31	26	0	0	0	0	0	0	0	15.56	0	0
2025	10	11	19	33	31	26	0	0	0	0	0	0	0	15.51	0	0
2025	10	11	19	43	31	26	0	0	0	0	0	0	0	15.46	0	0
2025	10	11	19	53	31	26	0	0	0	0	0	0	0	15.41	0	0
2025	10	11	20	3	31	27	0	0	0	0	0	0	0	15.37	0	0
2025	10	11	20	13	31	26	0	0	0	0	0	0	0	15.32	0	0
2025	10	11	20	23	31	26	0	0	0	0	0	0	0	15.26	0	0
2025	10	11	20	33	31	27	0	0	0	0	0	0	0	15.21	0	0
2025	10	11	20	43	31	26	0	0	0	0	0	0	0	15.17	0	0
2025	10	11	20	53	31	27	0	0	0	0	0	0	0	15.12	0	0
2025	10	11	21	3	31	26	0	0	0	0	0	0	0	15.07	0	0
2025	10	11	21	13	31	26	0	0	0	0	0	0	0	15.04	0	0
2025	10	11	21	23	31	26	0	0	0	0	0	0	0	14.99	0	0
2025	10	11	21	33	31	26	0	0	0	0	0	0	0	14.95	0	0
2025	10	11	21	43	31	26	0	0	0	0	0	0	0	14.9	0	0
2025	10	11	21	53	31	27	0	0	0	0	0	0	0	14.85	0	0
2025	10	11	22	3	31	26	0	0	0	0	0	0	0	14.82	0	0
2025	10	11	22	13	31	27	0	0	0	0	0	0	0	14.77	0	0
2025	10	11	22	23	31	26	0	0	0	0	0	0	0	14.74	0	0
2025	10	11	22	33	31	26	0	0	0	0	0	0	0	14.69	0	0
2025	10	11	22	43	31	27	0	0	0	0	0	0	0	14.65	0	0
2025	10	11	22	53	31	26	0	0	0	0	0	0	0	14.61	0	0
2025	10	11	23	3	31	27	0	0	0	0	0	0	0	14.56	0	0
2025	10	11	23	13	31	26	0	0	0	0	0	0	0	14.53	0	0
2025	10	11	23	23	31	26	0	0	0	0	0	0	0	14.48	0	0
2025	10	11	23	33	31	26	0	0	0	0	0	0	0	14.44	0	0
2025	10	11	23	43	31	26	0	0	0	0	0	0	0	14.4	0	0
2025	10	11	23	53	31	27	0	0	0	0	0	0	0	14.36	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	10	12	0	3	31	27	0	0	0	0	0	0	0	14.32	0	0
	2025	10	12	0	13	31	27	0	0	0	0	0	0	0	14.28	0	0
	2025	10	12	0	23	31	26	0	0	0	0	0	0	0	14.26	0	0
	2025	10	12	0	33	31	26	0	0	0	0	0	0	0	14.22	0	0
	2025	10	12	0	43	31	27	0	0	0	0	0	0	0	14.18	0	0
	2025	10	12	0	53	31	27	0	0	0	0	0	0	0	14.15	0	0
	2025	10	12	1	3	31	27	0	0	0	0	0	0	0	14.12	0	0
	2025	10	12	1	13	31	26	0	0	0	0	0	0	0	14.09	0	0
	2025	10	12	1	23	31	27	0	0	0	0	0	0	0	14.06	0	0
	2025	10	12	1	33	31	27	0	0	0	0	0	0	0	14.03	0	0
	2025	10	12	1	43	31	27	0	0	0	0	0	0	0	14.01	0	0
	2025	10	12	1	53	31	26	0	0	0	0	0	0	0	13.98	0	0
	2025	10	12	2	3	31	26	0	0	0	0	0	0	0	13.95	0	0
	2025	10	12	2	13	31	26	0	0	0	0	0	0	0	13.93	0	0
	2025	10	12	2	23	31	26	0	0	0	0	0	0	0	13.9	0	0
	2025	10	12	2	33	31	26	0	0	0	0	0	0	0	13.87	0	0
	2025	10	12	2	43	31	27	0	0	0	0	0	0	0	13.85	0	0
	2025	10	12	2	53	31	27	0	0	0	0	0	0	0	13.81	0	0
	2025	10	12	3	3	31	26	0	0	0	0	0	0	0	13.78	0	0
	2025	10	12	3	13	31	27	0	0	0	0	0	0	0	13.76	0	0
	2025	10	12	3	23	31	27	0	0	0	0	0	0	0	13.73	0	0
	2025	10	12	3	33	31	27	0	0	0	0	0	0	0	13.71	0	0
	2025	10	12	3	43	31	27	0	0	0	0	0	0	0	13.68	0	0
	2025	10	12	3	53	31	26	0	0	0	0	0	0	0	13.66	0	0
	2025	10	12	4	3	31	27	0	0	0	0	0	0	0	13.63	0	0
	2025	10	12	4	13	31	27	0	0	0	0	0	0	0	13.6	0	0
	2025	10	12	4	23	31	27	0	0	0	0	0	0	0	13.58	0	0
	2025	10	12	4	33	31	26	0	0	0	0	0	0	0	13.56	0	0
	2025	10	12	4	43	31	26	0	0	0	0	0	0	0	13.53	0	0
	2025	10	12	4	53	31	27	0	0	0	0	0	0	0	13.51	0	0
	2025	10	12	5	3	31	27	0	0	0	0	0	0	0	13.48	0	0
	2025	10	12	5	13	31	27	0	0	0	0	0	0	0	13.45	0	0
	2025	10	12	5	23	31	27	0	0	0	0	0	0	0	13.43	0	0
	2025	10	12	5	33	31	27	0	0	0	0	0	0	0	13.4	0	0
	2025	10	12	5	43	31	26	0	0	0	0	0	0	0	13.37	0	0
	2025	10	12	5	53	31	26	0	0	0	0	0	0	0	13.35	0	0
	2025	10	12	6	3	31	26	0	0	0	0	0	0	0	13.32	0	0
	2025	10	12	6	13	31	26	0	0	0	0	0	0	0	13.3	0	0
	2025	10	12	6	23	31	27	0	0	0	0	0	0	0	13.27	0	0
	2025	10	12	6	33	31	26	0	0	0	0	0	0	0	13.24	0	0
	2025	10	12	6	43	31	27	0	0	0	0	0	0	0	13.22	0	0
	2025	10	12	6	53	31	27	0	0	0	0	0	0	0	13.19	0	0
	2025	10	12	7	3	31	26	0	0	0	0	0	0	0	13.16	0	0
	2025	10	12	7	13	31	26	0	0	0	0	0	0	0	13.14	0	0
	2025	10	12	7	23	31	27	0	0	0	0	0	0	0	13.11	0	0
	2025	10	12	7	33	31	27	0	0	0	0	0	0	0	13.08	0	0
	2025	10	12	7	43	31	27	0	0	0	0	0	0	0	13.05	0	0
	2025	10	12	7	53	31	27	0	0	0	0	0	0	0	13.02	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	12	8	3	31	27	0	0	0	0	0	0	0	13	0	0
2025	10	12	8	13	31	27	0	0	0	0	0	0	0	12.97	0	0
2025	10	12	8	23	31	27	0	0	0	0	0	0	0	12.95	0	0
2025	10	12	8	33	31	27	0	0	0	0	0	0	0	12.94	0	0
2025	10	12	8	43	31	27	0	0	0	0	0	0	0	12.93	0	0
2025	10	12	8	53	31	27	0	0	0	0	0	0	0	12.93	0	0
2025	10	12	9	3	31	27	0	0	0	0	0	0	0	12.93	0	0
2025	10	12	9	13	31	27	0	0	0	0	0	0	0	12.93	0	0
2025	10	12	9	23	31	27	0	0	0	0	0	0	0	12.94	0	0
2025	10	12	9	33	31	27	0	0	0	0	0	0	0	12.96	0	0
2025	10	12	9	43	31	27	0	0	0	0	0	0	0	12.97	0	0
2025	10	12	9	53	31	27	0	0	0	0	0	0	0	12.99	0	0
2025	10	12	10	3	31	27	0	0	0	0	0	0	0	13.02	0	0
2025	10	12	10	13	31	27	0	0	0	0	0	0	0	13.05	0	0
2025	10	12	10	23	31	26	0	0	0	0	0	0	0	13.08	0	0
2025	10	12	10	33	31	27	0	0	0	0	0	0	0	13.11	0	0
2025	10	12	10	43	31	26	0	0	0	0	0	0	0	13.16	0	0
2025	10	12	10	53	31	27	0	0	0	0	0	0	0	13.2	0	0
2025	10	12	11	3	31	27	0	0	0	0	0	0	0	13.24	0	0
2025	10	12	11	13	31	26	0	0	0	0	0	0	0	13.28	0	0
2025	10	12	11	23	31	27	0	0	0	0	0	0	0	13.33	0	0
2025	10	12	11	33	31	27	0	0	0	0	0	0	0	13.37	0	0
2025	10	12	11	43	31	27	0	0	0	0	0	0	0	13.43	0	0
2025	10	12	11	53	31	26	0	0	0	0	0	0	0	13.48	0	0
2025	10	12	12	3	31	27	0	0	0	0	0	0	0	13.53	0	0
2025	10	12	12	13	31	26	0	0	0	0	0	0	0	13.58	0	0
2025	10	12	12	23	31	26	0	0	0	0	0	0	0	13.64	0	0
2025	10	12	12	33	31	26	0	0	0	0	0	0	0	13.69	0	0
2025	10	12	12	43	31	26	0	0	0	0	0	0	0	13.74	0	0
2025	10	12	12	53	31	26	0	0	0	0	0	0	0	13.79	0	0
2025	10	12	13	3	31	26	0	0	0	0	0	0	0	13.85	0	0
2025	10	12	13	13	31	27	0	0	0	0	0	0	0	13.9	0	0
2025	10	12	13	23	31	27	0	0	0	0	0	0	0	13.96	0	0
2025	10	12	13	33	31	27	0	0	0	0	0	0	0	14.01	0	0
2025	10	12	13	43	31	27	0	0	0	0	0	0	0	14.05	0	0
2025	10	12	13	53	31	26	0	0	0	0	0	0	0	14.09	0	0
2025	10	12	14	3	31	26	0	0	0	0	0	0	0	14.15	0	0
2025	10	12	14	13	31	27	0	0	0	0	0	0	0	14.18	0	0
2025	10	12	14	23	31	26	0	0	0	0	0	0	0	14.23	0	0
2025	10	12	14	33	31	27	0	0	0	0	0	0	0	14.27	0	0
2025	10	12	14	43	31	27	0	0	0	0	0	0	0	14.3	0	0
2025	10	12	14	53	31	26	0	0	0	0	0	0	0	14.33	0	0
2025	10	12	15	3	31	27	0	0	0	0	0	0	0	14.36	0	0
2025	10	12	15	13	31	27	0	0	0	0	0	0	0	14.39	0	0
2025	10	12	15	23	31	26	0	0	0	0	0	0	0	14.42	0	0
2025	10	12	15	33	31	27	0	0	0	0	0	0	0	14.45	0	0
2025	10	12	15	43	31	27	0	0	0	0	0	0	0	14.47	0	0
2025	10	12	15	53	31	26	0	0	0	0	0	0	0	14.49	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	12	16	3	31	27	0	0	0	0	0	0	0	14.5	0	0
2025	10	12	16	13	31	26	0	0	0	0	0	0	0	14.51	0	0
2025	10	12	16	23	31	26	0	0	0	0	0	0	0	14.51	0	0
2025	10	12	16	33	31	26	0	0	0	0	0	0	0	14.53	0	0
2025	10	12	16	43	31	27	0	0	0	0	0	0	0	14.52	0	0
2025	10	12	16	53	31	26	0	0	0	0	0	0	0	14.52	0	0
2025	10	12	17	3	31	27	0	0	0	0	0	0	0	14.52	0	0
2025	10	12	17	13	31	26	0	0	0	0	0	0	0	14.51	0	0
2025	10	12	17	23	31	26	0	0	0	0	0	0	0	14.5	0	0
2025	10	12	17	33	31	27	0	0	0	0	0	0	0	14.49	0	0
2025	10	12	17	43	31	27	0	0	0	0	0	0	0	14.48	0	0
2025	10	12	17	53	31	26	0	0	0	0	0	0	0	14.45	0	0
2025	10	12	18	3	31	26	0	0	0	0	0	0	0	14.44	0	0
2025	10	12	18	13	31	27	0	0	0	0	0	0	0	14.41	0	0
2025	10	12	18	23	31	27	0	0	0	0	0	0	0	14.39	0	0
2025	10	12	18	33	31	27	0	0	0	0	0	0	0	14.36	0	0
2025	10	12	18	43	31	26	0	0	0	0	0	0	0	14.33	0	0
2025	10	12	18	53	31	26	0	0	0	0	0	0	0	14.3	0	0
2025	10	12	19	3	31	26	0	0	0	0	0	0	0	14.26	0	0
2025	10	12	19	13	31	26	0	0	0	0	0	0	0	14.23	0	0
2025	10	12	19	23	31	27	0	0	0	0	0	0	0	14.19	0	0
2025	10	12	19	33	31	27	0	0	0	0	0	0	0	14.15	0	0
2025	10	12	19	43	31	26	0	0	0	0	0	0	0	14.1	0	0
2025	10	12	19	53	31	27	0	0	0	0	0	0	0	14.06	0	0
2025	10	12	20	3	31	27	0	0	0	0	0	0	0	14.01	0	0
2025	10	12	20	13	31	26	0	0	0	0	0	0	0	13.96	0	0
2025	10	12	20	23	31	27	0	0	0	0	0	0	0	13.91	0	0
2025	10	12	20	33	31	26	0	0	0	0	0	0	0	13.86	0	0
2025	10	12	20	43	31	26	0	0	0	0	0	0	0	13.82	0	0
2025	10	12	20	53	31	27	0	0	0	0	0	0	0	13.77	0	0
2025	10	12	21	3	31	26	0	0	0	0	0	0	0	13.72	0	0
2025	10	12	21	13	31	27	0	0	0	0	0	0	0	13.68	0	0
2025	10	12	21	23	31	27	0	0	0	0	0	0	0	13.63	0	0
2025	10	12	21	33	31	26	0	0	0	0	0	0	0	13.58	0	0
2025	10	12	21	43	31	27	0	0	0	0	0	0	0	13.54	0	0
2025	10	12	21	53	31	26	0	0	0	0	0	0	0	13.49	0	0
2025	10	12	22	3	31	27	0	0	0	0	0	0	0	13.44	0	0
2025	10	12	22	13	31	27	0	0	0	0	0	0	0	13.4	0	0
2025	10	12	22	23	31	27	0	0	0	0	0	0	0	13.36	0	0
2025	10	12	22	33	31	26	0	0	0	0	0	0	0	13.31	0	0
2025	10	12	22	43	31	26	0	0	0	0	0	0	0	13.26	0	0
2025	10	12	22	53	31	27	0	0	0	0	0	0	0	13.22	0	0
2025	10	12	23	3	31	26	0	0	0	0	0	0	0	13.17	0	0
2025	10	12	23	13	31	27	0	0	0	0	0	0	0	13.13	0	0
2025	10	12	23	23	31	27	0	0	0	0	0	0	0	13.08	0	0
2025	10	12	23	33	31	27	0	0	0	0	0	0	0	13.04	0	0
2025	10	12	23	43	31	28	0	0	0	0	0	0	0	13	0	0
2025	10	12	23	53	31	26	0	0	0	0	0	0	0	12.95	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	13	8	3	31	27	0	0	0	0	0	0	0	11.61	0	0
2025	10	13	8	13	31	27	0	0	0	0	0	0	0	11.59	0	0
2025	10	13	8	23	31	27	0	0	0	0	0	0	0	11.57	0	0
2025	10	13	8	33	31	27	0	0	0	0	0	0	0	11.56	0	0
2025	10	13	8	43	31	27	0	0	0	0	0	0	0	11.56	0	0
2025	10	13	8	53	31	27	0	0	0	0	0	0	0	11.56	0	0
2025	10	13	9	3	31	27	0	0	0	0	0	0	0	11.57	0	0
2025	10	13	9	13	31	27	0	0	0	0	0	0	0	11.58	0	0
2025	10	13	9	23	31	28	0	0	0	0	0	0	0	11.6	0	0
2025	10	13	9	33	31	27	0	0	0	0	0	0	0	11.62	0	0
2025	10	13	9	43	31	27	0	0	0	0	0	0	0	11.64	0	0
2025	10	13	9	53	31	27	0	0	0	0	0	0	0	11.67	0	0
2025	10	13	10	3	31	27	0	0	0	0	0	0	0	11.72	0	0
2025	10	13	10	13	31	27	0	0	0	0	0	0	0	11.73	0	0
2025	10	13	10	23	31	27	0	0	0	0	0	0	0	11.79	0	0
2025	10	13	10	33	31	26	0	0	0	0	0	0	0	11.84	0	0
2025	10	13	10	43	31	27	0	0	0	0	0	0	0	11.89	0	0
2025	10	13	10	53	31	27	0	0	0	0	0	0	0	11.92	0	0
2025	10	13	11	3	31	27	0	0	0	0	0	0	0	11.95	0	0
2025	10	13	11	13	31	27	0	0	0	0	0	0	0	12	0	0
2025	10	13	11	23	31	27	0	0	0	0	0	0	0	12.03	0	0
2025	10	13	11	33	31	27	0	0	0	0	0	0	0	12.07	0	0
2025	10	13	11	43	31	27	0	0	0	0	0	0	0	12.11	0	0
2025	10	13	11	53	31	28	0	0	0	0	0	0	0	12.17	0	0
2025	10	13	12	3	31	27	0	0	0	0	0	0	0	12.25	0	0
2025	10	13	12	13	31	27	0	0	0	0	0	0	0	12.33	0	0
2025	10	13	12	23	31	27	0	0	0	0	0	0	0	12.38	0	0
2025	10	13	12	33	31	26	0	0	0	0	0	0	0	12.44	0	0
2025	10	13	12	43	31	28	0	0	0	0	0	0	0	12.49	0	0
2025	10	13	12	53	31	27	0	0	0	0	0	0	0	12.55	0	0
2025	10	13	13	3	31	27	0	0	0	0	0	0	0	12.59	0	0
2025	10	13	13	13	31	26	0	0	0	0	0	0	0	12.6	0	0
2025	10	13	13	23	31	27	0	0	0	0	0	0	0	12.63	0	0
2025	10	13	13	33	31	26	0	0	0	0	0	0	0	12.69	0	0
2025	10	13	13	43	31	27	0	0	0	0	0	0	0	12.74	0	0
2025	10	13	13	53	31	26	0	0	0	0	0	0	0	12.78	0	0
2025	10	13	14	3	31	27	0	0	0	0	0	0	0	12.83	0	0
2025	10	13	14	13	31	26	0	0	0	0	0	0	0	12.84	0	0
2025	10	13	14	23	31	27	0	0	0	0	0	0	0	12.85	0	0
2025	10	13	14	33	31	27	0	0	0	0	0	0	0	12.86	0	0
2025	10	13	14	43	31	27	0	0	0	0	0	0	0	12.87	0	0
2025	10	13	14	53	31	26	0	0	0	0	0	0	0	12.89	0	0
2025	10	13	15	3	31	27	0	0	0	0	0	0	0	12.91	0	0
2025	10	13	15	13	31	27	0	0	0	0	0	0	0	12.91	0	0
2025	10	13	15	23	31	27	0	0	0	0	0	0	0	12.92	0	0
2025	10	13	15	33	31	27	0	0	0	0	0	0	0	12.92	0	0
2025	10	13	15	43	31	26	0	0	0	0	0	0	0	12.92	0	0
2025	10	13	15	53	31	27	0	0	0	0	0	0	0	12.93	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	13	16	3	31	28	0	0	0	0	0	0	0	12.93	0	0
2025	10	13	16	13	31	27	0	0	0	0	0	0	0	12.94	0	0
2025	10	13	16	23	31	27	0	0	0	0	0	0	0	12.96	0	0
2025	10	13	16	33	31	27	0	0	0	0	0	0	0	12.96	0	0
2025	10	13	16	43	31	27	0	0	0	0	0	0	0	12.97	0	0
2025	10	13	16	53	31	27	0	0	0	0	0	0	0	12.98	0	0
2025	10	13	17	3	31	27	0	0	0	0	0	0	0	12.98	0	0
2025	10	13	17	13	31	28	0	0	0	0	0	0	0	12.99	0	0
2025	10	13	17	23	31	27	0	0	0	0	0	0	0	12.98	0	0
2025	10	13	17	33	31	27	0	0	0	0	0	0	0	12.99	0	0
2025	10	13	17	43	31	27	0	0	0	0	0	0	0	12.97	0	0
2025	10	13	17	53	31	27	0	0	0	0	0	0	0	12.96	0	0
2025	10	13	18	3	31	27	0	0	0	0	0	0	0	12.95	0	0
2025	10	13	18	13	31	27	0	0	0	0	0	0	0	12.93	0	0
2025	10	13	18	23	31	27	0	0	0	0	0	0	0	12.92	0	0
2025	10	13	18	33	31	27	0	0	0	0	0	0	0	12.9	0	0
2025	10	13	18	43	31	27	0	0	0	0	0	0	0	12.89	0	0
2025	10	13	18	53	31	26	0	0	0	0	0	0	0	12.86	0	0
2025	10	13	19	3	31	26	0	0	0	0	0	0	0	12.83	0	0
2025	10	13	19	13	31	27	0	0	0	0	0	0	0	12.79	0	0
2025	10	13	19	23	31	27	0	0	0	0	0	0	0	12.76	0	0
2025	10	13	19	33	31	27	0	0	0	0	0	0	0	12.73	0	0
2025	10	13	19	43	31	26	0	0	0	0	0	0	0	12.71	0	0
2025	10	13	19	53	31	27	0	0	0	0	0	0	0	12.68	0	0
2025	10	13	20	3	31	26	0	0	0	0	0	0	0	12.65	0	0
2025	10	13	20	13	31	27	0	0	0	0	0	0	0	12.62	0	0
2025	10	13	20	23	31	27	0	0	0	0	0	0	0	12.6	0	0
2025	10	13	20	33	31	27	0	0	0	0	0	0	0	12.58	0	0
2025	10	13	20	43	31	27	0	0	0	0	0	0	0	12.55	0	0
2025	10	13	20	53	31	26	0	0	0	0	0	0	0	12.53	0	0
2025	10	13	21	3	31	26	0	0	0	0	0	0	0	12.51	0	0
2025	10	13	21	13	31	27	0	0	0	0	0	0	0	12.48	0	0
2025	10	13	21	23	31	27	0	0	0	0	0	0	0	12.46	0	0
2025	10	13	21	33	31	26	0	0	0	0	0	0	0	12.44	0	0
2025	10	13	21	43	31	27	0	0	0	0	0	0	0	12.42	0	0
2025	10	13	21	53	31	27	0	0	0	0	0	0	0	12.39	0	0
2025	10	13	22	3	31	26	0	0	0	0	0	0	0	12.38	0	0
2025	10	13	22	13	31	27	0	0	0	0	0	0	0	12.36	0	0
2025	10	13	22	23	31	27	0	0	0	0	0	0	0	12.33	0	0
2025	10	13	22	33	31	26	0	0	0	0	0	0	0	12.32	0	0
2025	10	13	22	43	31	28	0	0	0	0	0	0	0	12.3	0	0
2025	10	13	22	53	31	27	0	0	0	0	0	0	0	12.28	0	0
2025	10	13	23	3	31	26	0	0	0	0	0	0	0	12.26	0	0
2025	10	13	23	13	31	27	0	0	0	0	0	0	0	12.25	0	0
2025	10	13	23	23	31	27	0	0	0	0	0	0	0	12.23	0	0
2025	10	13	23	33	31	27	0	0	0	0	0	0	0	12.21	0	0
2025	10	13	23	43	31	27	0	0	0	0	0	0	0	12.19	0	0
2025	10	13	23	53	31	27	0	0	0	0	0	0	0	12.18	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	14	8	3	31	27	0	0	0	0	0	0	0	12.01	0	0
2025	10	14	8	13	31	27	0	0	0	0	0	0	0	12	0	0
2025	10	14	8	23	31	27	0	0	0	0	0	0	0	12	0	0
2025	10	14	8	33	31	27	0	0	0	0	0	0	0	11.99	0	0
2025	10	14	8	43	31	27	0	0	0	0	0	0	0	11.98	0	0
2025	10	14	8	53	31	26	0	0	0	0	0	0	0	11.97	0	0
2025	10	14	9	3	31	27	0	0	0	0	0	0	0	11.96	0	0
2025	10	14	9	13	31	27	0	0	0	0	0	0	0	11.96	0	0
2025	10	14	9	23	31	27	0	0	0	0	0	0	0	11.95	0	0
2025	10	14	9	33	31	27	0	0	0	0	0	0	0	11.95	0	0
2025	10	14	9	43	31	27	0	0	0	0	0	0	0	11.94	0	0
2025	10	14	9	53	31	27	0	0	0	0	0	0	0	11.93	0	0
2025	10	14	10	3	31	27	0	0	0	0	0	0	0	11.92	0	0
2025	10	14	10	13	31	27	0	0	0	0	0	0	0	11.92	0	0
2025	10	14	10	23	31	27	0	0	0	0	0	0	0	11.92	0	0
2025	10	14	10	33	31	26	0	0	0	0	0	0	0	11.91	0	0
2025	10	14	10	43	31	27	0	0	0	0	0	0	0	11.91	0	0
2025	10	14	10	53	31	28	0	0	0	0	0	0	0	11.9	0	0
2025	10	14	11	3	31	27	0	0	0	0	0	0	0	11.9	0	0
2025	10	14	11	13	31	27	0	0	0	0	0	0	0	11.9	0	0
2025	10	14	11	23	31	27	0	0	0	0	0	0	0	11.9	0	0
2025	10	14	11	33	31	27	0	0	0	0	0	0	0	11.89	0	0
2025	10	14	11	43	31	27	0	0	0	0	0	0	0	11.89	0	0
2025	10	14	11	53	31	27	0	0	0	0	0	0	0	11.88	0	0
2025	10	14	12	3	31	27	0	0	0	0	0	0	0	11.88	0	0
2025	10	14	12	13	31	27	0	0	0	0	0	0	0	11.87	0	0
2025	10	14	12	23	31	27	0	0	0	0	0	0	0	11.87	0	0
2025	10	14	12	33	31	26	0	0	0	0	0	0	0	11.86	0	0
2025	10	14	12	43	31	26	0	0	0	0	0	0	0	11.85	0	0
2025	10	14	12	53	31	27	0	0	0	0	0	0	0	11.84	0	0
2025	10	14	13	3	31	27	0	0	0	0	0	0	0	11.83	0	0
2025	10	14	13	13	31	28	0	0	0	0	0	0	0	11.82	0	0
2025	10	14	13	23	31	27	0	0	0	0	0	0	0	11.81	0	0
2025	10	14	13	33	31	27	0	0	0	0	0	0	0	11.8	0	0
2025	10	14	13	43	31	26	0	0	0	0	0	0	0	11.79	0	0
2025	10	14	13	53	31	27	0	0	0	0	0	0	0	11.77	0	0
2025	10	14	14	3	31	27	0	0	0	0	0	0	0	11.76	0	0
2025	10	14	14	13	31	27	0	0	0	0	0	0	0	11.74	0	0
2025	10	14	14	23	31	27	0	0	0	0	0	0	0	11.73	0	0
2025	10	14	14	33	31	28	0	0	0	0	0	0	0	11.72	0	0
2025	10	14	14	43	31	27	0	0	0	0	0	0	0	11.77	0	0
2025	10	14	14	53	31	27	0	0	0	0	0	0	0	11.79	0	0
2025	10	14	15	3	31	27	0	0	0	0	0	0	0	11.78	0	0
2025	10	14	15	13	31	27	0	0	0	0	0	0	0	11.78	0	0
2025	10	14	15	23	31	28	0	0	0	0	0	0	0	11.75	0	0
2025	10	14	15	33	31	27	0	0	0	0	0	0	0	11.73	0	0
2025	10	14	15	43	31	27	0	0	0	0	0	0	0	11.75	0	0
2025	10	14	15	53	31	27	0	0	0	0	0	0	0	11.78	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	14	16	3	31	27	0	0	0	0	0	0	0	11.79	0	0
2025	10	14	16	13	31	27	0	0	0	0	0	0	0	11.78	0	0
2025	10	14	16	23	31	27	0	0	0	0	0	0	0	11.76	0	0
2025	10	14	16	33	31	27	0	0	0	0	0	0	0	11.75	0	0
2025	10	14	16	43	31	27	0	0	0	0	0	0	0	11.73	0	0
2025	10	14	16	53	31	27	0	0	0	0	0	0	0	11.73	0	0
2025	10	14	17	3	31	27	0	0	0	0	0	0	0	11.71	0	0
2025	10	14	17	13	31	27	0	0	0	0	0	0	0	11.69	0	0
2025	10	14	17	23	31	27	0	0	0	0	0	0	0	11.66	0	0
2025	10	14	17	33	31	27	0	0	0	0	0	0	0	11.64	0	0
2025	10	14	17	43	31	27	0	0	0	0	0	0	0	11.61	0	0
2025	10	14	17	53	31	27	0	0	0	0	0	0	0	11.58	0	0
2025	10	14	18	3	31	27	0	0	0	0	0	0	0	11.56	0	0
2025	10	14	18	13	31	27	0	0	0	0	0	0	0	11.53	0	0
2025	10	14	18	23	31	27	0	0	0	0	0	0	0	11.5	0	0
2025	10	14	18	33	31	27	0	0	0	0	0	0	0	11.47	0	0
2025	10	14	18	43	31	27	0	0	0	0	0	0	0	11.45	0	0
2025	10	14	18	53	31	27	0	0	0	0	0	0	0	11.42	0	0
2025	10	14	19	3	31	27	0	0	0	0	0	0	0	11.4	0	0
2025	10	14	19	13	31	27	0	0	0	0	0	0	0	11.37	0	0
2025	10	14	19	23	31	27	0	0	0	0	0	0	0	11.35	0	0
2025	10	14	19	33	31	27	0	0	0	0	0	0	0	11.31	0	0
2025	10	14	19	43	31	28	0	0	0	0	0	0	0	11.29	0	0
2025	10	14	19	53	31	27	0	0	0	0	0	0	0	11.26	0	0
2025	10	14	20	3	31	27	0	0	0	0	0	0	0	11.24	0	0
2025	10	14	20	13	31	27	0	0	0	0	0	0	0	11.21	0	0
2025	10	14	20	23	31	27	0	0	0	0	0	0	0	11.19	0	0
2025	10	14	20	33	31	27	0	0	0	0	0	0	0	11.16	0	0
2025	10	14	20	43	31	27	0	0	0	0	0	0	0	11.14	0	0
2025	10	14	20	53	31	27	0	0	0	0	0	0	0	11.12	0	0
2025	10	14	21	3	31	27	0	0	0	0	0	0	0	11.1	0	0
2025	10	14	21	13	31	27	0	0	0	0	0	0	0	11.09	0	0
2025	10	14	21	23	31	28	0	0	0	0	0	0	0	11.07	0	0
2025	10	14	21	33	31	27	0	0	0	0	0	0	0	11.05	0	0
2025	10	14	21	43	31	27	0	0	0	0	0	0	0	11.04	0	0
2025	10	14	21	53	31	27	0	0	0	0	0	0	0	11.02	0	0
2025	10	14	22	3	31	27	0	0	0	0	0	0	0	11	0	0
2025	10	14	22	13	31	27	0	0	0	0	0	0	0	10.99	0	0
2025	10	14	22	23	31	28	0	0	0	0	0	0	0	10.98	0	0
2025	10	14	22	33	31	27	0	0	0	0	0	0	0	10.97	0	0
2025	10	14	22	43	31	27	0	0	0	0	0	0	0	10.96	0	0
2025	10	14	22	53	31	27	0	0	0	0	0	0	0	10.95	0	0
2025	10	14	23	3	31	27	0	0	0	0	0	0	0	10.93	0	0
2025	10	14	23	13	31	27	0	0	0	0	0	0	0	10.91	0	0
2025	10	14	23	23	31	27	0	0	0	0	0	0	0	10.9	0	0
2025	10	14	23	33	31	27	0	0	0	0	0	0	0	10.88	0	0
2025	10	14	23	43	31	27	0	0	0	0	0	0	0	10.87	0	0
2025	10	14	23	53	31	27	0	0	0	0	0	0	0	10.85	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	10	15	8	3	31	27	0	0	0	0	0	0	0	9.77	0	0
	2025	10	15	8	13	31	28	0	0	0	0	0	0	0	9.75	0	0
	2025	10	15	8	23	31	27	0	0	0	0	0	0	0	9.74	0	0
	2025	10	15	8	40	0	28	0	0	0	0	0	0	0	9.72	0	0
	2025	10	15	8	50	0	28	0	0	0	0	0	0	0	9.72	0	0
	2025	10	15	9	0	0	27	0	0	0	0	0	0	0	9.71	0	0
	2025	10	15	9	10	0	27	0	0	0	0	0	0	0	9.72	0	0
	2025	10	15	9	20	0	28	0	0	0	0	0	0	0	9.72	0	0
	2025	10	15	9	30	0	28	0	0	0	0	0	0	0	9.73	0	0
	2025	10	15	9	40	0	27	0	0	0	0	0	0	0	9.75	0	0
	2025	10	15	9	50	0	28	0	0	0	0	0	0	0	9.77	0	0
	2025	10	15	10	0	0	28	0	0	0	0	0	0	0	9.79	0	0
	2025	10	15	10	10	0	28	0	0	0	0	0	0	0	9.82	0	0
	2025	10	15	10	20	0	28	0	0	0	0	0	0	0	9.85	0	0
	2025	10	15	10	30	0	28	0	0	0	0	0	0	0	9.88	0	0
	2025	10	15	10	40	0	27	0	0	0	0	0	0	0	9.92	0	0
	2025	10	15	10	50	0	28	0	0	0	0	0	0	0	9.96	0	0
	2025	10	15	11	0	0	27	0	0	0	0	0	0	0	10	0	0
	2025	10	15	11	10	0	28	0	0	0	0	0	0	0	10.06	0	0
	2025	10	15	11	20	0	27	0	0	0	0	0	0	0	10.1	0	0
	2025	10	15	11	30	0	28	0	0	0	0	0	0	0	10.15	0	0
	2025	10	15	11	40	0	27	0	0	0	0	0	0	0	10.21	0	0
	2025	10	15	11	50	0	28	0	0	0	0	0	0	0	10.25	0	0
	2025	10	15	12	0	0	27	0	0	0	0	0	0	0	10.31	0	0
	2025	10	15	12	10	0	28	0	0	0	0	0	0	0	10.36	0	0
	2025	10	15	12	20	0	27	0	0	0	0	0	0	0	10.41	0	0
	2025	10	15	12	30	0	27	0	0	0	0	0	0	0	10.47	0	0
	2025	10	15	12	40	0	27	0	0	0	0	0	0	0	10.53	0	0
	2025	10	15	12	50	0	27	0	0	0	0	0	0	0	10.59	0	0
	2025	10	15	13	0	0	28	0	0	0	0	0	0	0	10.65	0	0
	2025	10	15	13	10	0	27	0	0	0	0	0	0	0	10.71	0	0
	2025	10	15	13	20	0	27	0	0	0	0	0	0	0	10.76	0	0
	2025	10	15	13	30	0	27	0	0	0	0	0	0	0	10.82	0	0
	2025	10	15	13	40	0	28	0	0	0	0	0	0	0	10.88	0	0
	2025	10	15	13	50	0	27	0	0	0	0	0	0	0	10.93	0	0
	2025	10	15	14	0	0	27	0	0	0	0	0	0	0	10.99	0	0
	2025	10	15	14	10	0	28	0	0	0	0	0	0	0	11.05	0	0
	2025	10	15	14	20	0	27	0	0	0	0	0	0	0	11.1	0	0
	2025	10	15	14	30	0	27	0	0	0	0	0	0	0	11.15	0	0
	2025	10	15	14	40	0	27	0	0	0	0	0	0	0	11.19	0	0
	2025	10	15	14	50	0	27	0	0	0	0	0	0	0	11.25	0	0
	2025	10	15	15	0	0	27	0	0	0	0	0	0	0	11.29	0	0
	2025	10	15	15	10	0	27	0	0	0	0	0	0	0	11.33	0	0
	2025	10	15	15	20	0	27	0	0	0	0	0	0	0	11.38	0	0
	2025	10	15	15	30	0	27	0	0	0	0	0	0	0	11.42	0	0
	2025	10	15	15	40	0	27	0	0	0	0	0	0	0	11.46	0	0
	2025	10	15	15	50	0	27	0	0	0	0	0	0	0	11.49	0	0
	2025	10	15	16	0	0	27	0	0	0	0	0	0	0	11.52	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	10	15	16	10	0	26	0	0	0	0	0	0	0	11.54	0	0
	2025	10	15	16	20	0	27	0	0	0	0	0	0	0	11.56	0	0
	2025	10	15	16	30	0	27	0	0	0	0	0	0	0	11.58	0	0
	2025	10	15	16	40	0	27	0	0	0	0	0	0	0	11.6	0	0
	2025	10	15	16	50	0	27	0	0	0	0	0	0	0	11.62	0	0
	2025	10	15	17	0	0	27	0	0	0	0	0	0	0	11.63	0	0
	2025	10	15	17	10	0	27	0	0	0	0	0	0	0	11.64	0	0
	2025	10	15	17	20	0	28	0	0	0	0	0	0	0	11.65	0	0
	2025	10	15	17	30	0	27	0	0	0	0	0	0	0	11.65	0	0
	2025	10	15	17	40	0	27	0	0	0	0	0	0	0	11.65	0	0
	2025	10	15	17	50	0	27	0	0	0	0	0	0	0	11.65	0	0
	2025	10	15	18	0	0	27	0	0	0	0	0	0	0	11.64	0	0
	2025	10	15	18	10	0	26	0	0	0	0	0	0	0	11.63	0	0
	2025	10	15	18	20	0	27	0	0	0	0	0	0	0	11.61	0	0
	2025	10	15	18	30	0	27	0	0	0	0	0	0	0	11.59	0	0
	2025	10	15	18	40	0	27	0	0	0	0	0	0	0	11.57	0	0
	2025	10	15	18	50	0	27	0	0	0	0	0	0	0	11.55	0	0
	2025	10	15	19	0	0	27	0	0	0	0	0	0	0	11.53	0	0
	2025	10	15	19	10	0	26	0	0	0	0	0	0	0	11.5	0	0
	2025	10	15	19	20	0	27	0	0	0	0	0	0	0	11.46	0	0
	2025	10	15	19	30	0	27	0	0	0	0	0	0	0	11.44	0	0
	2025	10	15	19	40	0	27	0	0	0	0	0	0	0	11.4	0	0
	2025	10	15	19	50	0	27	0	0	0	0	0	0	0	11.37	0	0
	2025	10	15	20	0	0	27	0	0	0	0	0	0	0	11.33	0	0
	2025	10	15	20	10	0	27	0	0	0	0	0	0	0	11.29	0	0
	2025	10	15	20	20	0	28	0	0	0	0	0	0	0	11.25	0	0
	2025	10	15	20	30	0	27	0	0	0	0	0	0	0	11.21	0	0
	2025	10	15	20	40	0	27	0	0	0	0	0	0	0	11.18	0	0
	2025	10	15	20	50	0	27	0	0	0	0	0	0	0	11.14	0	0
	2025	10	15	21	0	0	27	0	0	0	0	0	0	0	11.1	0	0
	2025	10	15	21	10	0	27	0	0	0	0	0	0	0	11.07	0	0
	2025	10	15	21	20	0	27	0	0	0	0	0	0	0	11.02	0	0
	2025	10	15	21	30	0	27	0	0	0	0	0	0	0	10.99	0	0
	2025	10	15	21	40	0	27	0	0	0	0	0	0	0	10.95	0	0
	2025	10	15	21	50	0	28	0	0	0	0	0	0	0	10.92	0	0
	2025	10	15	22	0	0	28	0	0	0	0	0	0	0	10.88	0	0
	2025	10	15	22	10	0	26	0	0	0	0	0	0	0	10.84	0	0
	2025	10	15	22	20	0	27	0	0	0	0	0	0	0	10.8	0	0
	2025	10	15	22	30	0	27	0	0	0	0	0	0	0	10.76	0	0
	2025	10	15	22	40	0	27	0	0	0	0	0	0	0	10.72	0	0
	2025	10	15	22	50	0	27	0	0	0	0	0	0	0	10.68	0	0
	2025	10	15	23	0	0	28	0	0	0	0	0	0	0	10.65	0	0
	2025	10	15	23	10	0	27	0	0	0	0	0	0	0	10.61	0	0
	2025	10	15	23	20	0	28	0	0	0	0	0	0	0	10.56	0	0
	2025	10	15	23	30	0	27	0	0	0	0	0	0	0	10.53	0	0
	2025	10	15	23	40	0	27	0	0	0	0	0	0	0	10.49	0	0
	2025	10	15	23	50	0	27	0	0	0	0	0	0	0	10.45	0	0
	2025	10	16	0	0	0	28	0	0	0	0	0	0	0	10.42	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	16	0	10	0	26	0	0	0	0	0	0	0	10.39	0	0
2025	10	16	0	20	0	28	0	0	0	0	0	0	0	10.35	0	0
2025	10	16	0	30	0	27	0	0	0	0	0	0	0	10.31	0	0
2025	10	16	0	40	0	27	0	0	0	0	0	0	0	10.28	0	0
2025	10	16	0	50	0	27	0	0	0	0	0	0	0	10.25	0	0
2025	10	16	1	0	0	28	0	0	0	0	0	0	0	10.21	0	0
2025	10	16	1	10	0	27	0	0	0	0	0	0	0	10.18	0	0
2025	10	16	1	20	0	27	0	0	0	0	0	0	0	10.15	0	0
2025	10	16	1	30	0	27	0	0	0	0	0	0	0	10.12	0	0
2025	10	16	1	40	0	27	0	0	0	0	0	0	0	10.09	0	0
2025	10	16	1	50	0	28	0	0	0	0	0	0	0	10.06	0	0
2025	10	16	2	0	0	27	0	0	0	0	0	0	0	10.03	0	0
2025	10	16	2	10	0	27	0	0	0	0	0	0	0	10.01	0	0
2025	10	16	2	20	0	27	0	0	0	0	0	0	0	9.98	0	0
2025	10	16	2	30	0	27	0	0	0	0	0	0	0	9.95	0	0
2025	10	16	2	40	0	28	0	0	0	0	0	0	0	9.92	0	0
2025	10	16	2	50	0	27	0	0	0	0	0	0	0	9.9	0	0
2025	10	16	3	0	0	27	0	0	0	0	0	0	0	9.87	0	0
2025	10	16	3	10	0	27	0	0	0	0	0	0	0	9.85	0	0
2025	10	16	3	20	0	28	0	0	0	0	0	0	0	9.83	0	0
2025	10	16	3	30	0	27	0	0	0	0	0	0	0	9.81	0	0
2025	10	16	3	40	0	27	0	0	0	0	0	0	0	9.79	0	0
2025	10	16	3	50	0	28	0	0	0	0	0	0	0	9.77	0	0
2025	10	16	4	0	0	27	0	0	0	0	0	0	0	9.75	0	0
2025	10	16	4	10	0	27	0	0	0	0	0	0	0	9.73	0	0
2025	10	16	4	20	0	27	0	0	0	0	0	0	0	9.7	0	0
2025	10	16	4	30	0	28	0	0	0	0	0	0	0	9.69	0	0
2025	10	16	4	40	0	27	0	0	0	0	0	0	0	9.67	0	0
2025	10	16	4	50	0	28	0	0	0	0	0	0	0	9.64	0	0
2025	10	16	5	0	0	27	0	0	0	0	0	0	0	9.62	0	0
2025	10	16	5	10	0	27	0	0	0	0	0	0	0	9.59	0	0
2025	10	16	5	20	0	28	0	0	0	0	0	0	0	9.57	0	0
2025	10	16	5	30	0	28	0	0	0	0	0	0	0	9.55	0	0
2025	10	16	5	40	0	28	0	0	0	0	0	0	0	9.53	0	0
2025	10	16	5	50	0	27	0	0	0	0	0	0	0	9.51	0	0
2025	10	16	6	0	0	27	0	0	0	0	0	0	0	9.5	0	0
2025	10	16	6	10	0	27	0	0	0	0	0	0	0	9.48	0	0
2025	10	16	6	20	0	28	0	0	0	0	0	0	0	9.46	0	0
2025	10	16	6	30	0	28	0	0	0	0	0	0	0	9.44	0	0
2025	10	16	6	40	0	28	0	0	0	0	0	0	0	9.43	0	0
2025	10	16	6	50	0	28	0	0	0	0	0	0	0	9.41	0	0
2025	10	16	7	0	0	27	0	0	0	0	0	0	0	9.4	0	0
2025	10	16	7	10	0	28	0	0	0	0	0	0	0	9.38	0	0
2025	10	16	7	20	0	27	0	0	0	0	0	0	0	9.37	0	0
2025	10	16	7	30	0	27	0	0	0	0	0	0	0	9.36	0	0
2025	10	16	7	40	0	27	0	0	0	0	0	0	0	9.34	0	0
2025	10	16	7	50	0	28	0	0	0	0	0	0	0	9.34	0	0
2025	10	16	8	0	0	27	0	0	0	0	0	0	0	9.32	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	17	0	10	0	28	0	0	0	0	0	0	0	11.03	0	0
2025	10	17	0	20	0	27	0	0	0	0	0	0	0	11.01	0	0
2025	10	17	0	30	0	27	0	0	0	0	0	0	0	11	0	0
2025	10	17	0	40	0	27	0	0	0	0	0	0	0	10.98	0	0
2025	10	17	0	50	0	27	0	0	0	0	0	0	0	10.96	0	0
2025	10	17	1	0	0	27	0	0	0	0	0	0	0	10.95	0	0
2025	10	17	1	10	0	27	0	0	0	0	0	0	0	10.93	0	0
2025	10	17	1	20	0	27	0	0	0	0	0	0	0	10.92	0	0
2025	10	17	1	30	0	28	0	0	0	0	0	0	0	10.9	0	0
2025	10	17	1	40	0	27	0	0	0	0	0	0	0	10.89	0	0
2025	10	17	1	50	0	27	0	0	0	0	0	0	0	10.88	0	0
2025	10	17	2	0	0	27	0	0	0	0	0	0	0	10.87	0	0
2025	10	17	2	10	0	27	0	0	0	0	0	0	0	10.86	0	0
2025	10	17	2	20	0	27	0	0	0	0	0	0	0	10.84	0	0
2025	10	17	2	30	0	27	0	0	0	0	0	0	0	10.84	0	0
2025	10	17	2	40	0	27	0	0	0	0	0	0	0	10.83	0	0
2025	10	17	2	50	0	27	0	0	0	0	0	0	0	10.82	0	0
2025	10	17	3	0	0	28	0	0	0	0	0	0	0	10.81	0	0
2025	10	17	3	10	0	28	0	0	0	0	0	0	0	10.8	0	0
2025	10	17	3	20	0	27	0	0	0	0	0	0	0	10.8	0	0
2025	10	17	3	30	0	27	0	0	0	0	0	0	0	10.79	0	0
2025	10	17	3	40	0	28	0	0	0	0	0	0	0	10.78	0	0
2025	10	17	3	50	0	27	0	0	0	0	0	0	0	10.77	0	0
2025	10	17	4	0	0	28	0	0	0	0	0	0	0	10.77	0	0
2025	10	17	4	10	0	27	0	0	0	0	0	0	0	10.76	0	0
2025	10	17	4	20	0	27	0	0	0	0	0	0	0	10.76	0	0
2025	10	17	4	30	0	27	0	0	0	0	0	0	0	10.75	0	0
2025	10	17	4	40	0	27	0	0	0	0	0	0	0	10.74	0	0
2025	10	17	4	50	0	27	0	0	0	0	0	0	0	10.74	0	0
2025	10	17	5	0	0	27	0	0	0	0	0	0	0	10.73	0	0
2025	10	17	5	10	0	27	0	0	0	0	0	0	0	10.72	0	0
2025	10	17	5	20	0	27	0	0	0	0	0	0	0	10.72	0	0
2025	10	17	5	30	0	27	0	0	0	0	0	0	0	10.71	0	0
2025	10	17	5	40	0	27	0	0	0	0	0	0	0	10.71	0	0
2025	10	17	5	50	0	27	0	0	0	0	0	0	0	10.7	0	0
2025	10	17	6	0	0	26	0	0	0	0	0	0	0	10.69	0	0
2025	10	17	6	10	0	27	0	0	0	0	0	0	0	10.69	0	0
2025	10	17	6	20	0	27	0	0	0	0	0	0	0	10.68	0	0
2025	10	17	6	30	0	27	0	0	0	0	0	0	0	10.67	0	0
2025	10	17	6	40	0	28	0	0	0	0	0	0	0	10.67	0	0
2025	10	17	6	50	0	28	0	0	0	0	0	0	0	10.66	0	0
2025	10	17	7	0	0	27	0	0	0	0	0	0	0	10.65	0	0
2025	10	17	7	10	0	27	0	0	0	0	0	0	0	10.64	0	0
2025	10	17	7	20	0	27	0	0	0	0	0	0	0	10.63	0	0
2025	10	17	7	30	0	28	0	0	0	0	0	0	0	10.62	0	0
2025	10	17	7	40	0	28	0	0	0	0	0	0	0	10.6	0	0
2025	10	17	7	50	0	27	0	0	0	0	0	0	0	10.59	0	0
2025	10	17	8	0	0	27	0	0	0	0	0	0	0	10.57	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	17	8	10	0	27	0	0	0	0	0	0	0	10.56	0	0
2025	10	17	8	20	0	27	0	0	0	0	0	0	0	10.56	0	0
2025	10	17	8	30	0	27	0	0	0	0	0	0	0	10.55	0	0
2025	10	17	8	40	0	28	0	0	0	0	0	0	0	10.55	0	0
2025	10	17	8	50	0	27	0	0	0	0	0	0	0	10.56	0	0
2025	10	17	9	0	0	28	0	0	0	0	0	0	0	10.57	0	0
2025	10	17	9	10	0	27	0	0	0	0	0	0	0	10.59	0	0
2025	10	17	9	20	0	28	0	0	0	0	0	0	0	10.61	0	0
2025	10	17	9	30	0	28	0	0	0	0	0	0	0	10.64	0	0
2025	10	17	9	40	0	27	0	0	0	0	0	0	0	10.66	0	0
2025	10	17	9	50	0	27	0	0	0	0	0	0	0	10.69	0	0
2025	10	17	10	0	0	28	0	0	0	0	0	0	0	10.73	0	0
2025	10	17	10	10	0	27	0	0	0	0	0	0	0	10.76	0	0
2025	10	17	10	20	0	27	0	0	0	0	0	0	0	10.8	0	0
2025	10	17	10	30	0	27	0	0	0	0	0	0	0	10.84	0	0
2025	10	17	10	40	0	27	0	0	0	0	0	0	0	10.88	0	0
2025	10	17	10	50	0	27	0	0	0	0	0	0	0	10.93	0	0
2025	10	17	11	0	0	27	0	0	0	0	0	0	0	10.98	0	0
2025	10	17	11	10	0	27	0	0	0	0	0	0	0	11.03	0	0
2025	10	17	11	20	0	27	0	0	0	0	0	0	0	11.08	0	0
2025	10	17	11	30	0	27	0	0	0	0	0	0	0	11.14	0	0
2025	10	17	11	40	0	27	0	0	0	0	0	0	0	11.2	0	0
2025	10	17	11	50	0	27	0	0	0	0	0	0	0	11.25	0	0
2025	10	17	12	0	0	27	0	0	0	0	0	0	0	11.31	0	0
2025	10	17	12	10	0	27	0	0	0	0	0	0	0	11.37	0	0
2025	10	17	12	20	0	28	0	0	0	0	0	0	0	11.43	0	0
2025	10	17	12	30	0	28	0	0	0	0	0	0	0	11.49	0	0
2025	10	17	12	40	0	27	0	0	0	0	0	0	0	11.54	0	0
2025	10	17	12	50	0	27	0	0	0	0	0	0	0	11.6	0	0
2025	10	17	13	0	0	27	0	0	0	0	0	0	0	11.66	0	0
2025	10	17	13	10	0	28	0	0	0	0	0	0	0	11.72	0	0
2025	10	17	13	20	0	28	0	0	0	0	0	0	0	11.78	0	0
2025	10	17	13	30	0	27	0	0	0	0	0	0	0	11.83	0	0
2025	10	17	13	40	0	27	0	0	0	0	0	0	0	11.89	0	0
2025	10	17	13	50	0	27	0	0	0	0	0	0	0	11.94	0	0
2025	10	17	14	0	0	27	0	0	0	0	0	0	0	12	0	0
2025	10	17	14	10	0	27	0	0	0	0	0	0	0	12.05	0	0
2025	10	17	14	20	0	26	0	0	0	0	0	0	0	12.1	0	0
2025	10	17	14	30	0	27	0	0	0	0	0	0	0	12.15	0	0
2025	10	17	14	40	0	28	0	0	0	0	0	0	0	12.2	0	0
2025	10	17	14	50	0	27	0	0	0	0	0	0	0	12.25	0	0
2025	10	17	15	0	0	27	0	0	0	0	0	0	0	12.29	0	0
2025	10	17	15	10	0	27	0	0	0	0	0	0	0	12.34	0	0
2025	10	17	15	20	0	27	0	0	0	0	0	0	0	12.37	0	0
2025	10	17	15	30	0	26	0	0	0	0	0	0	0	12.41	0	0
2025	10	17	15	40	0	27	0	0	0	0	0	0	0	12.44	0	0
2025	10	17	15	50	0	27	0	0	0	0	0	0	0	12.47	0	0
2025	10	17	16	0	0	27	0	0	0	0	0	0	0	12.51	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	10	17	16	10	0	27	0	0	0	0	0	0	0	12.53	0	0
	2025	10	17	16	20	0	27	0	0	0	0	0	0	0	12.55	0	0
	2025	10	17	16	30	0	27	0	0	0	0	0	0	0	12.57	0	0
	2025	10	17	16	40	0	27	0	0	0	0	0	0	0	12.58	0	0
	2025	10	17	16	50	0	27	0	0	0	0	0	0	0	12.6	0	0
	2025	10	17	17	0	0	27	0	0	0	0	0	0	0	12.62	0	0
	2025	10	17	17	10	0	27	0	0	0	0	0	0	0	12.62	0	0
	2025	10	17	17	20	0	28	0	0	0	0	0	0	0	12.63	0	0
	2025	10	17	17	30	0	27	0	0	0	0	0	0	0	12.63	0	0
	2025	10	17	17	40	0	27	0	0	0	0	0	0	0	12.63	0	0
	2025	10	17	17	50	0	27	0	0	0	0	0	0	0	12.63	0	0
	2025	10	17	18	0	0	27	0	0	0	0	0	0	0	12.62	0	0
	2025	10	17	18	10	0	27	0	0	0	0	0	0	0	12.61	0	0
	2025	10	17	18	20	0	27	0	0	0	0	0	0	0	12.59	0	0
	2025	10	17	18	30	0	27	0	0	0	0	0	0	0	12.57	0	0
	2025	10	17	18	40	0	27	0	0	0	0	0	0	0	12.56	0	0
	2025	10	17	18	50	0	28	0	0	0	0	0	0	0	12.53	0	0
	2025	10	17	19	0	0	27	0	0	0	0	0	0	0	12.51	0	0
	2025	10	17	19	10	0	27	0	0	0	0	0	0	0	12.48	0	0
	2025	10	17	19	20	0	27	0	0	0	0	0	0	0	12.45	0	0
	2025	10	17	19	30	0	26	0	0	0	0	0	0	0	12.42	0	0
	2025	10	17	19	40	0	27	0	0	0	0	0	0	0	12.39	0	0
	2025	10	17	19	50	0	26	0	0	0	0	0	0	0	12.35	0	0
	2025	10	17	20	0	0	27	0	0	0	0	0	0	0	12.32	0	0
	2025	10	17	20	10	0	27	0	0	0	0	0	0	0	12.28	0	0
	2025	10	17	20	20	0	27	0	0	0	0	0	0	0	12.25	0	0
	2025	10	17	20	30	0	27	0	0	0	0	0	0	0	12.21	0	0
	2025	10	17	20	40	0	26	0	0	0	0	0	0	0	12.18	0	0
	2025	10	17	20	50	0	27	0	0	0	0	0	0	0	12.14	0	0
	2025	10	17	21	0	0	27	0	0	0	0	0	0	0	12.11	0	0
	2025	10	17	21	10	0	27	0	0	0	0	0	0	0	12.07	0	0
	2025	10	17	21	20	0	27	0	0	0	0	0	0	0	12.04	0	0
	2025	10	17	21	30	0	27	0	0	0	0	0	0	0	12.01	0	0
	2025	10	17	21	40	0	27	0	0	0	0	0	0	0	11.97	0	0
	2025	10	17	21	50	0	27	0	0	0	0	0	0	0	11.93	0	0
	2025	10	17	22	0	0	27	0	0	0	0	0	0	0	11.89	0	0
	2025	10	17	22	10	0	27	0	0	0	0	0	0	0	11.86	0	0
	2025	10	17	22	20	0	27	0	0	0	0	0	0	0	11.82	0	0
	2025	10	17	22	30	0	28	0	0	0	0	0	0	0	11.79	0	0
	2025	10	17	22	40	0	27	0	0	0	0	0	0	0	11.76	0	0
	2025	10	17	22	50	0	27	0	0	0	0	0	0	0	11.72	0	0
	2025	10	17	23	0	0	27	0	0	0	0	0	0	0	11.69	0	0
	2025	10	17	23	10	0	26	0	0	0	0	0	0	0	11.66	0	0
	2025	10	17	23	20	0	27	0	0	0	0	0	0	0	11.63	0	0
	2025	10	17	23	30	0	27	0	0	0	0	0	0	0	11.6	0	0
	2025	10	17	23	40	0	27	0	0	0	0	0	0	0	11.56	0	0
	2025	10	17	23	50	0	27	0	0	0	0	0	0	0	11.53	0	0
	2025	10	18	0	0	0	27	0	0	0	0	0	0	0	11.5	0	0

Mazourka (0354)

	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	18	0	10	0	27	0	0	0	0	0	0	0	11.47	0	0
2025	10	18	0	20	0	28	0	0	0	0	0	0	0	11.45	0	0
2025	10	18	0	30	0	28	0	0	0	0	0	0	0	11.42	0	0
2025	10	18	0	40	0	27	0	0	0	0	0	0	0	11.39	0	0
2025	10	18	0	50	0	27	0	0	0	0	0	0	0	11.37	0	0
2025	10	18	1	0	0	26	0	0	0	0	0	0	0	11.34	0	0
2025	10	18	1	10	0	27	0	0	0	0	0	0	0	11.31	0	0
2025	10	18	1	20	0	28	0	0	0	0	0	0	0	11.28	0	0
2025	10	18	1	30	0	27	0	0	0	0	0	0	0	11.25	0	0
2025	10	18	1	40	0	27	0	0	0	0	0	0	0	11.23	0	0
2025	10	18	1	50	0	27	0	0	0	0	0	0	0	11.2	0	0
2025	10	18	2	0	0	27	0	0	0	0	0	0	0	11.18	0	0
2025	10	18	2	10	0	27	0	0	0	0	0	0	0	11.15	0	0
2025	10	18	2	20	0	27	0	0	0	0	0	0	0	11.13	0	0
2025	10	18	2	30	0	27	0	0	0	0	0	0	0	11.11	0	0
2025	10	18	2	40	0	27	0	0	0	0	0	0	0	11.09	0	0
2025	10	18	2	50	0	27	0	0	0	0	0	0	0	11.07	0	0
2025	10	18	3	0	0	27	0	0	0	0	0	0	0	11.05	0	0
2025	10	18	3	10	0	27	0	0	0	0	0	0	0	11.02	0	0
2025	10	18	3	20	0	27	0	0	0	0	0	0	0	11	0	0
2025	10	18	3	30	0	27	0	0	0	0	0	0	0	10.97	0	0
2025	10	18	3	40	0	27	0	0	0	0	0	0	0	10.95	0	0
2025	10	18	3	50	0	27	0	0	0	0	0	0	0	10.93	0	0
2025	10	18	4	0	0	27	0	0	0	0	0	0	0	10.91	0	0
2025	10	18	4	10	0	27	0	0	0	0	0	0	0	10.89	0	0
2025	10	18	4	20	0	27	0	0	0	0	0	0	0	10.87	0	0
2025	10	18	4	30	0	28	0	0	0	0	0	0	0	10.84	0	0
2025	10	18	4	40	0	28	0	0	0	0	0	0	0	10.83	0	0
2025	10	18	4	50	0	26	0	0	0	0	0	0	0	10.81	0	0
2025	10	18	5	0	0	27	0	0	0	0	0	0	0	10.78	0	0
2025	10	18	5	10	0	27	0	0	0	0	0	0	0	10.77	0	0
2025	10	18	5	20	0	28	0	0	0	0	0	0	0	10.75	0	0
2025	10	18	5	30	0	28	0	0	0	0	0	0	0	10.72	0	0
2025	10	18	5	40	0	27	0	0	0	0	0	0	0	10.7	0	0
2025	10	18	5	50	0	27	0	0	0	0	0	0	0	10.68	0	0
2025	10	18	6	0	0	27	0	0	0	0	0	0	0	10.66	0	0
2025	10	18	6	10	0	27	0	0	0	0	0	0	0	10.63	0	0
2025	10	18	6	20	0	27	0	0	0	0	0	0	0	10.62	0	0
2025	10	18	6	30	0	28	0	0	0	0	0	0	0	10.6	0	0
2025	10	18	6	40	0	26	0	0	0	0	0	0	0	10.58	0	0
2025	10	18	6	50	0	27	0	0	0	0	0	0	0	10.56	0	0
2025	10	18	7	0	0	27	0	0	0	0	0	0	0	10.53	0	0
2025	10	18	7	10	0	27	0	0	0	0	0	0	0	10.52	0	0
2025	10	18	7	20	0	28	0	0	0	0	0	0	0	10.5	0	0
2025	10	18	7	30	0	27	0	0	0	0	0	0	0	10.47	0	0
2025	10	18	7	40	0	28	0	0	0	0	0	0	0	10.46	0	0
2025	10	18	7	50	0	27	0	0	0	0	0	0	0	10.45	0	0
2025	10	18	8	0	0	27	0	0	0	0	0	0	0	10.43	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	10	18	16	10	0	28	0	0	0	0	0	0	0	12.48	0	0
	2025	10	18	16	20	0	27	0	0	0	0	0	0	0	12.5	0	0
	2025	10	18	16	30	0	26	0	0	0	0	0	0	0	12.52	0	0
	2025	10	18	16	40	0	27	0	0	0	0	0	0	0	12.53	0	0
	2025	10	18	16	50	0	27	0	0	0	0	0	0	0	12.55	0	0
	2025	10	18	17	0	0	27	0	0	0	0	0	0	0	12.56	0	0
	2025	10	18	17	10	0	27	0	0	0	0	0	0	0	12.57	0	0
	2025	10	18	17	20	0	27	0	0	0	0	0	0	0	12.58	0	0
	2025	10	18	17	30	0	27	0	0	0	0	0	0	0	12.58	0	0
	2025	10	18	17	40	0	26	0	0	0	0	0	0	0	12.59	0	0
	2025	10	18	17	50	0	27	0	0	0	0	0	0	0	12.58	0	0
	2025	10	18	18	0	0	27	0	0	0	0	0	0	0	12.58	0	0
	2025	10	18	18	10	0	26	0	0	0	0	0	0	0	12.56	0	0
	2025	10	18	18	20	0	27	0	0	0	0	0	0	0	12.55	0	0
	2025	10	18	18	30	0	26	0	0	0	0	0	0	0	12.54	0	0
	2025	10	18	18	40	0	27	0	0	0	0	0	0	0	12.52	0	0
	2025	10	18	18	50	0	27	0	0	0	0	0	0	0	12.5	0	0
	2025	10	18	19	0	0	27	0	0	0	0	0	0	0	12.48	0	0
	2025	10	18	19	10	0	27	0	0	0	0	0	0	0	12.46	0	0
	2025	10	18	19	20	0	27	0	0	0	0	0	0	0	12.43	0	0
	2025	10	18	19	30	0	27	0	0	0	0	0	0	0	12.4	0	0
	2025	10	18	19	40	0	27	0	0	0	0	0	0	0	12.37	0	0
	2025	10	18	19	50	0	27	0	0	0	0	0	0	0	12.34	0	0
	2025	10	18	20	0	0	27	0	0	0	0	0	0	0	12.31	0	0
	2025	10	18	20	10	0	27	0	0	0	0	0	0	0	12.27	0	0
	2025	10	18	20	20	0	26	0	0	0	0	0	0	0	12.24	0	0
	2025	10	18	20	30	0	27	0	0	0	0	0	0	0	12.21	0	0
	2025	10	18	20	40	0	27	0	0	0	0	0	0	0	12.17	0	0
	2025	10	18	20	50	0	27	0	0	0	0	0	0	0	12.14	0	0
	2025	10	18	21	0	0	27	0	0	0	0	0	0	0	12.1	0	0
	2025	10	18	21	10	0	26	0	0	0	0	0	0	0	12.07	0	0
	2025	10	18	21	20	0	27	0	0	0	0	0	0	0	12.03	0	0
	2025	10	18	21	30	0	27	0	0	0	0	0	0	0	12	0	0
	2025	10	18	21	40	0	27	0	0	0	0	0	0	0	11.96	0	0
	2025	10	18	21	50	0	27	0	0	0	0	0	0	0	11.93	0	0
	2025	10	18	22	0	0	27	0	0	0	0	0	0	0	11.9	0	0
	2025	10	18	22	10	0	27	0	0	0	0	0	0	0	11.87	0	0
	2025	10	18	22	20	0	27	0	0	0	0	0	0	0	11.84	0	0
	2025	10	18	22	30	0	27	0	0	0	0	0	0	0	11.81	0	0
	2025	10	18	22	40	0	27	0	0	0	0	0	0	0	11.79	0	0
	2025	10	18	22	50	0	28	0	0	0	0	0	0	0	11.75	0	0
	2025	10	18	23	0	0	27	0	0	0	0	0	0	0	11.72	0	0
	2025	10	18	23	10	0	27	0	0	0	0	0	0	0	11.68	0	0
	2025	10	18	23	20	0	27	0	0	0	0	0	0	0	11.65	0	0
	2025	10	18	23	30	0	27	0	0	0	0	0	0	0	11.63	0	0
	2025	10	18	23	40	0	27	0	0	0	0	0	0	0	11.6	0	0
	2025	10	18	23	50	0	28	0	0	0	0	0	0	0	11.57	0	0
	2025	10	19	0	0	0	27	0	0	0	0	0	0	0	11.54	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	19	0	10	0	26	0	0	0	0	0	0	0	11.52	0	0
2025	10	19	0	20	0	27	0	0	0	0	0	0	0	11.48	0	0
2025	10	19	0	30	0	27	0	0	0	0	0	0	0	11.47	0	0
2025	10	19	0	40	0	27	0	0	0	0	0	0	0	11.44	0	0
2025	10	19	0	50	0	27	0	0	0	0	0	0	0	11.41	0	0
2025	10	19	1	0	0	27	0	0	0	0	0	0	0	11.39	0	0
2025	10	19	1	10	0	27	0	0	0	0	0	0	0	11.37	0	0
2025	10	19	1	20	0	27	0	0	0	0	0	0	0	11.34	0	0
2025	10	19	1	30	0	28	0	0	0	0	0	0	0	11.32	0	0
2025	10	19	1	40	0	27	0	0	0	0	0	0	0	11.3	0	0
2025	10	19	1	50	0	27	0	0	0	0	0	0	0	11.28	0	0
2025	10	19	2	0	0	27	0	0	0	0	0	0	0	11.27	0	0
2025	10	19	2	10	0	27	0	0	0	0	0	0	0	11.24	0	0
2025	10	19	2	20	0	27	0	0	0	0	0	0	0	11.23	0	0
2025	10	19	2	30	0	27	0	0	0	0	0	0	0	11.21	0	0
2025	10	19	2	40	0	28	0	0	0	0	0	0	0	11.2	0	0
2025	10	19	2	50	0	27	0	0	0	0	0	0	0	11.19	0	0
2025	10	19	3	0	0	28	0	0	0	0	0	0	0	11.17	0	0
2025	10	19	3	10	0	27	0	0	0	0	0	0	0	11.16	0	0
2025	10	19	3	20	0	27	0	0	0	0	0	0	0	11.15	0	0
2025	10	19	3	30	0	27	0	0	0	0	0	0	0	11.13	0	0
2025	10	19	3	40	0	27	0	0	0	0	0	0	0	11.11	0	0
2025	10	19	3	50	0	27	0	0	0	0	0	0	0	11.11	0	0
2025	10	19	4	0	0	27	0	0	0	0	0	0	0	11.1	0	0
2025	10	19	4	10	0	27	0	0	0	0	0	0	0	11.08	0	0
2025	10	19	4	20	0	27	0	0	0	0	0	0	0	11.07	0	0
2025	10	19	4	30	0	27	0	0	0	0	0	0	0	11.05	0	0
2025	10	19	4	40	0	28	0	0	0	0	0	0	0	11.04	0	0
2025	10	19	4	50	0	27	0	0	0	0	0	0	0	11.03	0	0
2025	10	19	5	0	0	27	0	0	0	0	0	0	0	11.01	0	0
2025	10	19	5	10	0	28	0	0	0	0	0	0	0	11	0	0
2025	10	19	5	20	0	27	0	0	0	0	0	0	0	10.99	0	0
2025	10	19	5	30	0	26	0	0	0	0	0	0	0	10.97	0	0
2025	10	19	5	40	0	27	0	0	0	0	0	0	0	10.96	0	0
2025	10	19	5	50	0	27	0	0	0	0	0	0	0	10.94	0	0
2025	10	19	6	0	0	27	0	0	0	0	0	0	0	10.93	0	0
2025	10	19	6	10	0	27	0	0	0	0	0	0	0	10.91	0	0
2025	10	19	6	20	0	27	0	0	0	0	0	0	0	10.89	0	0
2025	10	19	6	30	0	28	0	0	0	0	0	0	0	10.88	0	0
2025	10	19	6	40	0	27	0	0	0	0	0	0	0	10.86	0	0
2025	10	19	6	50	0	27	0	0	0	0	0	0	0	10.84	0	0
2025	10	19	7	0	0	27	0	0	0	0	0	0	0	10.82	0	0
2025	10	19	7	10	0	27	0	0	0	0	0	0	0	10.81	0	0
2025	10	19	7	20	0	28	0	0	0	0	0	0	0	10.79	0	0
2025	10	19	7	30	0	27	0	0	0	0	0	0	0	10.78	0	0
2025	10	19	7	40	0	27	0	0	0	0	0	0	0	10.76	0	0
2025	10	19	7	50	0	28	0	0	0	0	0	0	0	10.74	0	0
2025	10	19	8	0	0	27	0	0	0	0	0	0	0	10.72	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	10	20	16	10	0	26	0	0	0	0	0	0	0	13.28	0	0
	2025	10	20	16	20	0	27	0	0	0	0	0	0	0	13.3	0	0
	2025	10	20	16	30	0	28	0	0	0	0	0	0	0	13.33	0	0
	2025	10	20	16	40	0	27	0	0	0	0	0	0	0	13.35	0	0
	2025	10	20	16	50	0	27	0	0	0	0	0	0	0	13.37	0	0
	2025	10	20	17	0	0	27	0	0	0	0	0	0	0	13.39	0	0
	2025	10	20	17	10	0	27	0	0	0	0	0	0	0	13.41	0	0
	2025	10	20	17	20	0	28	0	0	0	0	0	0	0	13.43	0	0
	2025	10	20	17	30	0	27	0	0	0	0	0	0	0	13.44	0	0
	2025	10	20	17	40	0	27	0	0	0	0	0	0	0	13.44	0	0
	2025	10	20	17	50	0	27	0	0	0	0	0	0	0	13.45	0	0
	2025	10	20	18	0	0	27	0	0	0	0	0	0	0	13.44	0	0
	2025	10	20	18	10	0	26	0	0	0	0	0	0	0	13.44	0	0
	2025	10	20	18	20	0	27	0	0	0	0	0	0	0	13.43	0	0
	2025	10	20	18	30	0	26	0	0	0	0	0	0	0	13.42	0	0
	2025	10	20	18	40	0	26	0	0	0	0	0	0	0	13.4	0	0
	2025	10	20	18	50	0	27	0	0	0	0	0	0	0	13.39	0	0
	2025	10	20	19	0	0	27	0	0	0	0	0	0	0	13.36	0	0
	2025	10	20	19	10	0	27	0	0	0	0	0	0	0	13.35	0	0
	2025	10	20	19	20	0	27	0	0	0	0	0	0	0	13.32	0	0
	2025	10	20	19	30	0	27	0	0	0	0	0	0	0	13.29	0	0
	2025	10	20	19	40	0	27	0	0	0	0	0	0	0	13.27	0	0
	2025	10	20	19	50	0	27	0	0	0	0	0	0	0	13.24	0	0
	2025	10	20	20	0	0	27	0	0	0	0	0	0	0	13.21	0	0
	2025	10	20	20	10	0	26	0	0	0	0	0	0	0	13.17	0	0
	2025	10	20	20	20	0	26	0	0	0	0	0	0	0	13.14	0	0
	2025	10	20	20	30	0	27	0	0	0	0	0	0	0	13.11	0	0
	2025	10	20	20	40	0	27	0	0	0	0	0	0	0	13.07	0	0
	2025	10	20	20	50	0	27	0	0	0	0	0	0	0	13.04	0	0
	2025	10	20	21	0	0	28	0	0	0	0	0	0	0	13	0	0
	2025	10	20	21	10	0	27	0	0	0	0	0	0	0	12.97	0	0
	2025	10	20	21	20	0	27	0	0	0	0	0	0	0	12.93	0	0
	2025	10	20	21	30	0	26	0	0	0	0	0	0	0	12.9	0	0
	2025	10	20	21	40	0	27	0	0	0	0	0	0	0	12.86	0	0
	2025	10	20	21	50	0	28	0	0	0	0	0	0	0	12.83	0	0
	2025	10	20	22	0	0	27	0	0	0	0	0	0	0	12.79	0	0
	2025	10	20	22	10	0	27	0	0	0	0	0	0	0	12.76	0	0
	2025	10	20	22	20	0	27	0	0	0	0	0	0	0	12.73	0	0
	2025	10	20	22	30	0	27	0	0	0	0	0	0	0	12.69	0	0
	2025	10	20	22	40	0	27	0	0	0	0	0	0	0	12.65	0	0
	2025	10	20	22	50	0	27	0	0	0	0	0	0	0	12.62	0	0
	2025	10	20	23	0	0	27	0	0	0	0	0	0	0	12.59	0	0
	2025	10	20	23	10	0	27	0	0	0	0	0	0	0	12.55	0	0
	2025	10	20	23	20	0	27	0	0	0	0	0	0	0	12.51	0	0
	2025	10	20	23	30	0	27	0	0	0	0	0	0	0	12.48	0	0
	2025	10	20	23	40	0	27	0	0	0	0	0	0	0	12.44	0	0
	2025	10	20	23	50	0	26	0	0	0	0	0	0	0	12.4	0	0
	2025	10	21	0	0	0	27	0	0	0	0	0	0	0	12.37	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	21	0	10	0	27	0	0	0	0	0	0	0	12.34	0	0
2025	10	21	0	20	0	27	0	0	0	0	0	0	0	12.3	0	0
2025	10	21	0	30	0	26	0	0	0	0	0	0	0	12.27	0	0
2025	10	21	0	40	0	27	0	0	0	0	0	0	0	12.24	0	0
2025	10	21	0	50	0	27	0	0	0	0	0	0	0	12.21	0	0
2025	10	21	1	0	0	27	0	0	0	0	0	0	0	12.17	0	0
2025	10	21	1	10	0	27	0	0	0	0	0	0	0	12.14	0	0
2025	10	21	1	20	0	27	0	0	0	0	0	0	0	12.11	0	0
2025	10	21	1	30	0	27	0	0	0	0	0	0	0	12.08	0	0
2025	10	21	1	40	0	27	0	0	0	0	0	0	0	12.04	0	0
2025	10	21	1	50	0	27	0	0	0	0	0	0	0	12.01	0	0
2025	10	21	2	0	0	27	0	0	0	0	0	0	0	11.99	0	0
2025	10	21	2	10	0	27	0	0	0	0	0	0	0	11.96	0	0
2025	10	21	2	20	0	27	0	0	0	0	0	0	0	11.94	0	0
2025	10	21	2	30	0	27	0	0	0	0	0	0	0	11.91	0	0
2025	10	21	2	40	0	27	0	0	0	0	0	0	0	11.9	0	0
2025	10	21	2	50	0	27	0	0	0	0	0	0	0	11.87	0	0
2025	10	21	3	0	0	27	0	0	0	0	0	0	0	11.85	0	0
2025	10	21	3	10	0	28	0	0	0	0	0	0	0	11.83	0	0
2025	10	21	3	20	0	27	0	0	0	0	0	0	0	11.82	0	0
2025	10	21	3	30	0	27	0	0	0	0	0	0	0	11.8	0	0
2025	10	21	3	40	0	26	0	0	0	0	0	0	0	11.78	0	0
2025	10	21	3	50	0	27	0	0	0	0	0	0	0	11.76	0	0
2025	10	21	4	0	0	27	0	0	0	0	0	0	0	11.74	0	0
2025	10	21	4	10	0	27	0	0	0	0	0	0	0	11.73	0	0
2025	10	21	4	20	0	27	0	0	0	0	0	0	0	11.71	0	0
2025	10	21	4	30	0	27	0	0	0	0	0	0	0	11.7	0	0
2025	10	21	4	40	0	27	0	0	0	0	0	0	0	11.68	0	0
2025	10	21	4	50	0	27	0	0	0	0	0	0	0	11.67	0	0
2025	10	21	5	0	0	27	0	0	0	0	0	0	0	11.65	0	0
2025	10	21	5	10	0	26	0	0	0	0	0	0	0	11.64	0	0
2025	10	21	5	20	0	27	0	0	0	0	0	0	0	11.62	0	0
2025	10	21	5	30	0	27	0	0	0	0	0	0	0	11.6	0	0
2025	10	21	5	40	0	27	0	0	0	0	0	0	0	11.59	0	0
2025	10	21	5	50	0	28	0	0	0	0	0	0	0	11.57	0	0
2025	10	21	6	0	0	27	0	0	0	0	0	0	0	11.55	0	0
2025	10	21	6	10	0	27	0	0	0	0	0	0	0	11.54	0	0
2025	10	21	6	20	0	27	0	0	0	0	0	0	0	11.53	0	0
2025	10	21	6	30	0	27	0	0	0	0	0	0	0	11.5	0	0
2025	10	21	6	40	0	27	0	0	0	0	0	0	0	11.49	0	0
2025	10	21	6	50	0	27	0	0	0	0	0	0	0	11.48	0	0
2025	10	21	7	0	0	27	0	0	0	0	0	0	0	11.46	0	0
2025	10	21	7	10	0	27	0	0	0	0	0	0	0	11.44	0	0
2025	10	21	7	20	0	28	0	0	0	0	0	0	0	11.43	0	0
2025	10	21	7	30	0	27	0	0	0	0	0	0	0	11.42	0	0
2025	10	21	7	40	0	27	0	0	0	0	0	0	0	11.4	0	0
2025	10	21	7	50	0	27	0	0	0	0	0	0	0	11.39	0	0
2025	10	21	8	0	0	27	0	0	0	0	0	0	0	11.38	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	22	8	10	0	27	0	0	0	0	0	0	0	12.59	0	0
2025	10	22	8	20	0	27	0	0	0	0	0	0	0	12.59	0	0
2025	10	22	8	30	0	27	0	0	0	0	0	0	0	12.6	0	0
2025	10	22	8	40	0	27	0	0	0	0	0	0	0	12.61	0	0
2025	10	22	8	50	0	27	0	0	0	0	0	0	0	12.62	0	0
2025	10	22	9	0	0	27	0	0	0	0	0	0	0	12.64	0	0
2025	10	22	9	10	0	26	0	0	0	0	0	0	0	12.66	0	0
2025	10	22	9	20	0	27	0	0	0	0	0	0	0	12.68	0	0
2025	10	22	9	30	0	27	0	0	0	0	0	0	0	12.71	0	0
2025	10	22	9	40	0	27	0	0	0	0	0	0	0	12.75	0	0
2025	10	22	9	50	0	27	0	0	0	0	0	0	0	12.77	0	0
2025	10	22	10	0	0	27	0	0	0	0	0	0	0	12.82	0	0
2025	10	22	10	10	0	27	0	0	0	0	0	0	0	12.86	0	0
2025	10	22	10	20	0	27	0	0	0	0	0	0	0	12.89	0	0
2025	10	22	10	30	0	27	0	0	0	0	0	0	0	12.91	0	0
2025	10	22	10	40	0	27	0	0	0	0	0	0	0	12.96	0	0
2025	10	22	10	50	0	27	0	0	0	0	0	0	0	13	0	0
2025	10	22	11	0	0	27	0	0	0	0	0	0	0	13.06	0	0
2025	10	22	11	10	0	26	0	0	0	0	0	0	0	13.12	0	0
2025	10	22	11	20	0	27	0	0	0	0	0	0	0	13.16	0	0
2025	10	22	11	30	0	27	0	0	0	0	0	0	0	13.23	0	0
2025	10	22	11	40	0	27	0	0	0	0	0	0	0	13.3	0	0
2025	10	22	11	50	0	27	0	0	0	0	0	0	0	13.36	0	0
2025	10	22	12	0	0	27	0	0	0	0	0	0	0	13.42	0	0
2025	10	22	12	10	0	26	0	0	0	0	0	0	0	13.48	0	0
2025	10	22	12	20	0	27	0	0	0	0	0	0	0	13.53	0	0
2025	10	22	12	30	0	27	0	0	0	0	0	0	0	13.61	0	0
2025	10	22	12	40	0	27	0	0	0	0	0	0	0	13.68	0	0
2025	10	22	12	50	0	27	0	0	0	0	0	0	0	13.75	0	0
2025	10	22	13	0	0	26	0	0	0	0	0	0	0	13.82	0	0
2025	10	22	13	10	0	27	0	0	0	0	0	0	0	13.89	0	0
2025	10	22	13	20	0	26	0	0	0	0	0	0	0	13.95	0	0
2025	10	22	13	30	0	27	0	0	0	0	0	0	0	14.01	0	0
2025	10	22	13	40	0	27	0	0	0	0	0	0	0	14.01	0	0
2025	10	22	13	50	0	27	0	0	0	0	0	0	0	14.02	0	0
2025	10	22	14	0	0	26	0	0	0	0	0	0	0	14.05	0	0
2025	10	22	14	10	0	27	0	0	0	0	0	0	0	14.08	0	0
2025	10	22	14	20	0	27	0	0	0	0	0	0	0	14.1	0	0
2025	10	22	14	30	0	26	0	0	0	0	0	0	0	14.13	0	0
2025	10	22	14	40	0	26	0	0	0	0	0	0	0	14.15	0	0
2025	10	22	14	50	0	27	0	0	0	0	0	0	0	14.17	0	0
2025	10	22	15	0	0	26	0	0	0	0	0	0	0	14.19	0	0
2025	10	22	15	10	0	27	0	0	0	0	0	0	0	14.23	0	0
2025	10	22	15	20	0	26	0	0	0	0	0	0	0	14.26	0	0
2025	10	22	15	30	0	27	0	0	0	0	0	0	0	14.27	0	0
2025	10	22	15	40	0	27	0	0	0	0	0	0	0	14.26	0	0
2025	10	22	15	50	0	27	0	0	0	0	0	0	0	14.26	0	0
2025	10	22	16	0	0	26	0	0	0	0	0	0	0	14.27	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	10	22	16	10	0	27	0	0	0	0	0	0	0	14.28	0	0
	2025	10	22	16	20	0	27	0	0	0	0	0	0	0	14.29	0	0
	2025	10	22	16	30	0	27	0	0	0	0	0	0	0	14.3	0	0
	2025	10	22	16	40	0	26	0	0	0	0	0	0	0	14.29	0	0
	2025	10	22	16	50	0	26	0	0	0	0	0	0	0	14.29	0	0
	2025	10	22	17	0	0	26	0	0	0	0	0	0	0	14.28	0	0
	2025	10	22	17	10	0	27	0	0	0	0	0	0	0	14.27	0	0
	2025	10	22	17	20	0	27	0	0	0	0	0	0	0	14.27	0	0
	2025	10	22	17	30	0	27	0	0	0	0	0	0	0	14.26	0	0
	2025	10	22	17	40	0	27	0	0	0	0	0	0	0	14.25	0	0
	2025	10	22	17	50	0	27	0	0	0	0	0	0	0	14.24	0	0
	2025	10	22	18	0	0	27	0	0	0	0	0	0	0	14.23	0	0
	2025	10	22	18	10	0	27	0	0	0	0	0	0	0	14.23	0	0
	2025	10	22	18	20	0	27	0	0	0	0	0	0	0	14.21	0	0
	2025	10	22	18	30	0	27	0	0	0	0	0	0	0	14.19	0	0
	2025	10	22	18	40	0	27	0	0	0	0	0	0	0	14.17	0	0
	2025	10	22	18	50	0	27	0	0	0	0	0	0	0	14.15	0	0
	2025	10	22	19	0	0	27	0	0	0	0	0	0	0	14.13	0	0
	2025	10	22	19	10	0	27	0	0	0	0	0	0	0	14.12	0	0
	2025	10	22	19	20	0	27	0	0	0	0	0	0	0	14.1	0	0
	2025	10	22	19	30	0	26	0	0	0	0	0	0	0	14.08	0	0
	2025	10	22	19	40	0	27	0	0	0	0	0	0	0	14.06	0	0
	2025	10	22	19	50	0	27	0	0	0	0	0	0	0	14.04	0	0
	2025	10	22	20	0	0	26	0	0	0	0	0	0	0	14.02	0	0
	2025	10	22	20	10	0	26	0	0	0	0	0	0	0	14.01	0	0
	2025	10	22	20	20	0	27	0	0	0	0	0	0	0	13.98	0	0
	2025	10	22	20	30	0	26	0	0	0	0	0	0	0	13.95	0	0
	2025	10	22	20	40	0	27	0	0	0	0	0	0	0	13.92	0	0
	2025	10	22	20	50	0	26	0	0	0	0	0	0	0	13.89	0	0
	2025	10	22	21	0	0	27	0	0	0	0	0	0	0	13.87	0	0
	2025	10	22	21	10	0	27	0	0	0	0	0	0	0	13.84	0	0
	2025	10	22	21	20	0	27	0	0	0	0	0	0	0	13.81	0	0
	2025	10	22	21	30	0	26	0	0	0	0	0	0	0	13.79	0	0
	2025	10	22	21	40	0	26	0	0	0	0	0	0	0	13.75	0	0
	2025	10	22	21	50	0	27	0	0	0	0	0	0	0	13.72	0	0
	2025	10	22	22	0	0	27	0	0	0	0	0	0	0	13.7	0	0
	2025	10	22	22	10	0	27	0	0	0	0	0	0	0	13.68	0	0
	2025	10	22	22	20	0	27	0	0	0	0	0	0	0	13.66	0	0
	2025	10	22	22	30	0	27	0	0	0	0	0	0	0	13.64	0	0
	2025	10	22	22	40	0	26	0	0	0	0	0	0	0	13.62	0	0
	2025	10	22	22	50	0	27	0	0	0	0	0	0	0	13.6	0	0
	2025	10	22	23	0	0	26	0	0	0	0	0	0	0	13.58	0	0
	2025	10	22	23	10	0	27	0	0	0	0	0	0	0	13.56	0	0
	2025	10	22	23	20	0	27	0	0	0	0	0	0	0	13.55	0	0
	2025	10	22	23	30	0	26	0	0	0	0	0	0	0	13.53	0	0
	2025	10	22	23	40	0	26	0	0	0	0	0	0	0	13.51	0	0
	2025	10	22	23	50	0	27	0	0	0	0	0	0	0	13.5	0	0
	2025	10	23	0	0	0	26	0	0	0	0	0	0	0	13.48	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

[illegible]

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	25	8	10	0	27	0	0	0	0	0	0	0	11.96	0	0
2025	10	25	8	20	0	27	0	0	0	0	0	0	0	11.95	0	0
2025	10	25	8	30	0	27	0	0	0	0	0	0	0	11.94	0	0
2025	10	25	8	40	0	27	0	0	0	0	0	0	0	11.94	0	0
2025	10	25	8	50	0	27	0	0	0	0	0	0	0	11.94	0	0
2025	10	25	9	0	0	27	0	0	0	0	0	0	0	11.93	0	0
2025	10	25	9	10	0	27	0	0	0	0	0	0	0	11.94	0	0
2025	10	25	9	20	0	27	0	0	0	0	0	0	0	11.94	0	0
2025	10	25	9	30	0	27	0	0	0	0	0	0	0	11.94	0	0
2025	10	25	9	40	0	27	0	0	0	0	0	0	0	11.94	0	0
2025	10	25	9	50	0	27	0	0	0	0	0	0	0	11.95	0	0
2025	10	25	10	0	0	27	0	0	0	0	0	0	0	11.96	0	0
2025	10	25	10	10	0	27	0	0	0	0	0	0	0	11.99	0	0
2025	10	25	10	20	0	27	0	0	0	0	0	0	0	12.01	0	0
2025	10	25	10	30	0	27	0	0	0	0	0	0	0	12.02	0	0
2025	10	25	10	40	0	27	0	0	0	0	0	0	0	12.07	0	0
2025	10	25	10	50	0	27	0	0	0	0	0	0	0	12.12	0	0
2025	10	25	11	0	0	27	0	0	0	0	0	0	0	12.16	0	0
2025	10	25	11	10	0	27	0	0	0	0	0	0	0	12.21	0	0
2025	10	25	11	20	0	27	0	0	0	0	0	0	0	12.24	0	0
2025	10	25	11	30	0	26	0	0	0	0	0	0	0	12.3	0	0
2025	10	25	11	40	0	27	0	0	0	0	0	0	0	12.33	0	0
2025	10	25	11	50	0	26	0	0	0	0	0	0	0	12.38	0	0
2025	10	25	12	0	0	27	0	0	0	0	0	0	0	12.48	0	0
2025	10	25	12	10	0	26	0	0	0	0	0	0	0	12.56	0	0
2025	10	25	12	20	0	27	0	0	0	0	0	0	0	12.59	0	0
2025	10	25	12	30	0	27	0	0	0	0	0	0	0	12.62	0	0
2025	10	25	12	40	0	27	0	0	0	0	0	0	0	12.74	0	0
2025	10	25	12	50	0	27	0	0	0	0	0	0	0	12.82	0	0
2025	10	25	13	0	0	27	0	0	0	0	0	0	0	12.88	0	0
2025	10	25	13	10	0	27	0	0	0	0	0	0	0	12.92	0	0
2025	10	25	13	20	0	27	0	0	0	0	0	0	0	13.01	0	0
2025	10	25	13	30	0	27	0	0	0	0	0	0	0	13.07	0	0
2025	10	25	13	40	0	26	0	0	0	0	0	0	0	13.11	0	0
2025	10	25	13	50	0	26	0	0	0	0	0	0	0	13.18	0	0
2025	10	25	14	0	0	28	0	0	0	0	0	0	0	13.23	0	0
2025	10	25	14	10	0	26	0	0	0	0	0	0	0	13.29	0	0
2025	10	25	14	20	0	27	0	0	0	0	0	0	0	13.34	0	0
2025	10	25	14	30	0	27	0	0	0	0	0	0	0	13.4	0	0
2025	10	25	14	40	0	26	0	0	0	0	0	0	0	13.44	0	0
2025	10	25	14	50	0	27	0	0	0	0	0	0	0	13.49	0	0
2025	10	25	15	0	0	27	0	0	0	0	0	0	0	13.52	0	0
2025	10	25	15	10	0	26	0	0	0	0	0	0	0	13.55	0	0
2025	10	25	15	20	0	27	0	0	0	0	0	0	0	13.58	0	0
2025	10	25	15	30	0	27	0	0	0	0	0	0	0	13.61	0	0
2025	10	25	15	40	0	27	0	0	0	0	0	0	0	13.66	0	0
2025	10	25	15	50	0	27	0	0	0	0	0	0	0	13.69	0	0
2025	10	25	16	0	0	27	0	0	0	0	0	0	0	13.71	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	26	0	10	0	27	0	0	0	0	0	0	0	12.75	0	0
2025	10	26	0	20	0	27	0	0	0	0	0	0	0	12.72	0	0
2025	10	26	0	30	0	26	0	0	0	0	0	0	0	12.69	0	0
2025	10	26	0	40	0	26	0	0	0	0	0	0	0	12.66	0	0
2025	10	26	0	50	0	27	0	0	0	0	0	0	0	12.63	0	0
2025	10	26	1	0	0	27	0	0	0	0	0	0	0	12.6	0	0
2025	10	26	1	10	0	27	0	0	0	0	0	0	0	12.57	0	0
2025	10	26	1	20	0	27	0	0	0	0	0	0	0	12.53	0	0
2025	10	26	1	30	0	27	0	0	0	0	0	0	0	12.5	0	0
2025	10	26	1	40	0	27	0	0	0	0	0	0	0	12.47	0	0
2025	10	26	1	50	0	27	0	0	0	0	0	0	0	12.45	0	0
2025	10	26	2	0	0	27	0	0	0	0	0	0	0	12.41	0	0
2025	10	26	2	10	0	26	0	0	0	0	0	0	0	12.39	0	0
2025	10	26	2	20	0	27	0	0	0	0	0	0	0	12.37	0	0
2025	10	26	2	30	0	27	0	0	0	0	0	0	0	12.34	0	0
2025	10	26	2	40	0	26	0	0	0	0	0	0	0	12.31	0	0
2025	10	26	2	50	0	26	0	0	0	0	0	0	0	12.28	0	0
2025	10	26	3	0	0	27	0	0	0	0	0	0	0	12.26	0	0
2025	10	26	3	10	0	27	0	0	0	0	0	0	0	12.24	0	0
2025	10	26	3	20	0	27	0	0	0	0	0	0	0	12.22	0	0
2025	10	26	3	30	0	27	0	0	0	0	0	0	0	12.2	0	0
2025	10	26	3	40	0	27	0	0	0	0	0	0	0	12.17	0	0
2025	10	26	3	50	0	27	0	0	0	0	0	0	0	12.16	0	0
2025	10	26	4	0	0	27	0	0	0	0	0	0	0	12.13	0	0
2025	10	26	4	10	0	27	0	0	0	0	0	0	0	12.12	0	0
2025	10	26	4	20	0	27	0	0	0	0	0	0	0	12.1	0	0
2025	10	26	4	30	0	26	0	0	0	0	0	0	0	12.08	0	0
2025	10	26	4	40	0	27	0	0	0	0	0	0	0	12.06	0	0
2025	10	26	4	50	0	26	0	0	0	0	0	0	0	12.04	0	0
2025	10	26	5	0	0	27	0	0	0	0	0	0	0	12.02	0	0
2025	10	26	5	10	0	27	0	0	0	0	0	0	0	12	0	0
2025	10	26	5	20	0	27	0	0	0	0	0	0	0	11.99	0	0
2025	10	26	5	30	0	27	0	0	0	0	0	0	0	11.98	0	0
2025	10	26	5	40	0	27	0	0	0	0	0	0	0	11.96	0	0
2025	10	26	5	50	0	27	0	0	0	0	0	0	0	11.95	0	0
2025	10	26	6	0	0	27	0	0	0	0	0	0	0	11.93	0	0
2025	10	26	6	10	0	27	0	0	0	0	0	0	0	11.92	0	0
2025	10	26	6	20	0	27	0	0	0	0	0	0	0	11.9	0	0
2025	10	26	6	30	0	27	0	0	0	0	0	0	0	11.89	0	0
2025	10	26	6	40	0	27	0	0	0	0	0	0	0	11.88	0	0
2025	10	26	6	50	0	27	0	0	0	0	0	0	0	11.86	0	0
2025	10	26	7	0	0	27	0	0	0	0	0	0	0	11.84	0	0
2025	10	26	7	10	0	27	0	0	0	0	0	0	0	11.83	0	0
2025	10	26	7	20	0	27	0	0	0	0	0	0	0	11.81	0	0
2025	10	26	7	30	0	28	0	0	0	0	0	0	0	11.8	0	0
2025	10	26	7	40	0	27	0	0	0	0	0	0	0	11.79	0	0
2025	10	26	7	50	0	27	0	0	0	0	0	0	0	11.77	0	0
2025	10	26	8	0	0	26	0	0	0	0	0	0	0	11.76	0	0

Mazourka (0354)

	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	26	8	10	0	26	0	0	0	0	0	0	0	11.75	0	0
2025	10	26	8	20	0	27	0	0	0	0	0	0	0	11.74	0	0
2025	10	26	8	30	0	27	0	0	0	0	0	0	0	11.73	0	0
2025	10	26	8	40	0	27	0	0	0	0	0	0	0	11.72	0	0
2025	10	26	8	50	0	27	0	0	0	0	0	0	0	11.72	0	0
2025	10	26	9	0	0	27	0	0	0	0	0	0	0	11.73	0	0
2025	10	26	9	10	0	26	0	0	0	0	0	0	0	11.73	0	0
2025	10	26	9	20	0	27	0	0	0	0	0	0	0	11.74	0	0
2025	10	26	9	30	0	27	0	0	0	0	0	0	0	11.76	0	0
2025	10	26	9	40	0	28	0	0	0	0	0	0	0	11.77	0	0
2025	10	26	9	50	0	28	0	0	0	0	0	0	0	11.79	0	0
2025	10	26	10	0	0	27	0	0	0	0	0	0	0	11.82	0	0
2025	10	26	10	10	0	28	0	0	0	0	0	0	0	11.85	0	0
2025	10	26	10	20	0	27	0	0	0	0	0	0	0	11.88	0	0
2025	10	26	10	30	0	27	0	0	0	0	0	0	0	11.92	0	0
2025	10	26	10	40	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	10	26	10	50	0	27	0	0	0	0	0	0	0	12.02	0	0
2025	10	26	11	0	0	27	0	0	0	0	0	0	0	12.07	0	0
2025	10	26	11	10	0	27	0	0	0	0	0	0	0	12.13	0	0
2025	10	26	11	20	0	27	0	0	0	0	0	0	0	12.18	0	0
2025	10	26	11	30	0	28	0	0	0	0	0	0	0	12.24	0	0
2025	10	26	11	40	0	28	0	0	0	0	0	0	0	12.31	0	0
2025	10	26	11	50	0	27	0	0	0	0	0	0	0	12.37	0	0
2025	10	26	12	0	0	27	0	0	0	0	0	0	0	12.44	0	0
2025	10	26	12	10	0	27	0	0	0	0	0	0	0	12.5	0	0
2025	10	26	12	20	0	27	0	0	0	0	0	0	0	12.56	0	0
2025	10	26	12	30	0	27	0	0	0	0	0	0	0	12.63	0	0
2025	10	26	12	40	0	27	0	0	0	0	0	0	0	12.68	0	0
2025	10	26	12	50	0	27	0	0	0	0	0	0	0	12.73	0	0
2025	10	26	13	0	0	26	0	0	0	0	0	0	0	12.8	0	0
2025	10	26	13	10	0	27	0	0	0	0	0	0	0	12.84	0	0
2025	10	26	13	20	0	27	0	0	0	0	0	0	0	12.9	0	0
2025	10	26	13	30	0	27	0	0	0	0	0	0	0	12.94	0	0
2025	10	26	13	40	0	26	0	0	0	0	0	0	0	12.99	0	0
2025	10	26	13	50	0	27	0	0	0	0	0	0	0	13.05	0	0
2025	10	26	14	0	0	27	0	0	0	0	0	0	0	13.1	0	0
2025	10	26	14	10	0	27	0	0	0	0	0	0	0	13.14	0	0
2025	10	26	14	20	0	26	0	0	0	0	0	0	0	13.16	0	0
2025	10	26	14	30	0	26	0	0	0	0	0	0	0	13.2	0	0
2025	10	26	14	40	0	27	0	0	0	0	0	0	0	13.25	0	0
2025	10	26	14	50	0	27	0	0	0	0	0	0	0	13.3	0	0
2025	10	26	15	0	0	26	0	0	0	0	0	0	0	13.36	0	0
2025	10	26	15	10	0	27	0	0	0	0	0	0	0	13.42	0	0
2025	10	26	15	20	0	27	0	0	0	0	0	0	0	13.46	0	0
2025	10	26	15	30	0	27	0	0	0	0	0	0	0	13.5	0	0
2025	10	26	15	40	0	26	0	0	0	0	0	0	0	13.53	0	0
2025	10	26	15	50	0	27	0	0	0	0	0	0	0	13.57	0	0
2025	10	26	16	0	0	27	0	0	0	0	0	0	0	13.6	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	10	26	16	10	0	26	0	0	0	0	0	0	0	13.63	0	0
	2025	10	26	16	20	0	26	0	0	0	0	0	0	0	13.65	0	0
	2025	10	26	16	30	0	27	0	0	0	0	0	0	0	13.68	0	0
	2025	10	26	16	40	0	26	0	0	0	0	0	0	0	13.7	0	0
	2025	10	26	16	50	0	27	0	0	0	0	0	0	0	13.72	0	0
	2025	10	26	17	0	0	27	0	0	0	0	0	0	0	13.74	0	0
	2025	10	26	17	10	0	27	0	0	0	0	0	0	0	13.75	0	0
	2025	10	26	17	20	0	27	0	0	0	0	0	0	0	13.76	0	0
	2025	10	26	17	30	0	26	0	0	0	0	0	0	0	13.77	0	0
	2025	10	26	17	40	0	27	0	0	0	0	0	0	0	13.78	0	0
	2025	10	26	17	50	0	27	0	0	0	0	0	0	0	13.78	0	0
	2025	10	26	18	0	0	27	0	0	0	0	0	0	0	13.77	0	0
	2025	10	26	18	10	0	27	0	0	0	0	0	0	0	13.77	0	0
	2025	10	26	18	20	0	27	0	0	0	0	0	0	0	13.76	0	0
	2025	10	26	18	30	0	27	0	0	0	0	0	0	0	13.76	0	0
	2025	10	26	18	40	0	27	0	0	0	0	0	0	0	13.75	0	0
	2025	10	26	18	50	0	27	0	0	0	0	0	0	0	13.74	0	0
	2025	10	26	19	0	0	27	0	0	0	0	0	0	0	13.73	0	0
	2025	10	26	19	10	0	27	0	0	0	0	0	0	0	13.7	0	0
	2025	10	26	19	20	0	27	0	0	0	0	0	0	0	13.69	0	0
	2025	10	26	19	30	0	26	0	0	0	0	0	0	0	13.66	0	0
	2025	10	26	19	40	0	27	0	0	0	0	0	0	0	13.64	0	0
	2025	10	26	19	50	0	26	0	0	0	0	0	0	0	13.61	0	0
	2025	10	26	20	0	0	26	0	0	0	0	0	0	0	13.58	0	0
	2025	10	26	20	10	0	27	0	0	0	0	0	0	0	13.55	0	0
	2025	10	26	20	20	0	26	0	0	0	0	0	0	0	13.52	0	0
	2025	10	26	20	30	0	26	0	0	0	0	0	0	0	13.49	0	0
	2025	10	26	20	40	0	26	0	0	0	0	0	0	0	13.45	0	0
	2025	10	26	20	50	0	27	0	0	0	0	0	0	0	13.42	0	0
	2025	10	26	21	0	0	27	0	0	0	0	0	0	0	13.38	0	0
	2025	10	26	21	10	0	26	0	0	0	0	0	0	0	13.35	0	0
	2025	10	26	21	20	0	27	0	0	0	0	0	0	0	13.32	0	0
	2025	10	26	21	30	0	27	0	0	0	0	0	0	0	13.28	0	0
	2025	10	26	21	40	0	27	0	0	0	0	0	0	0	13.25	0	0
	2025	10	26	21	50	0	26	0	0	0	0	0	0	0	13.22	0	0
	2025	10	26	22	0	0	26	0	0	0	0	0	0	0	13.19	0	0
	2025	10	26	22	10	0	26	0	0	0	0	0	0	0	13.15	0	0
	2025	10	26	22	20	0	27	0	0	0	0	0	0	0	13.11	0	0
	2025	10	26	22	30	0	27	0	0	0	0	0	0	0	13.08	0	0
	2025	10	26	22	40	0	27	0	0	0	0	0	0	0	13.05	0	0
	2025	10	26	22	50	0	27	0	0	0	0	0	0	0	13.02	0	0
	2025	10	26	23	0	0	27	0	0	0	0	0	0	0	12.98	0	0
	2025	10	26	23	10	0	26	0	0	0	0	0	0	0	12.95	0	0
	2025	10	26	23	20	0	27	0	0	0	0	0	0	0	12.91	0	0
	2025	10	26	23	30	0	26	0	0	0	0	0	0	0	12.88	0	0
	2025	10	26	23	40	0	27	0	0	0	0	0	0	0	12.84	0	0
	2025	10	26	23	50	0	27	0	0	0	0	0	0	0	12.81	0	0
	2025	10	27	0	0	0	28	0	0	0	0	0	0	0	12.78	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	27	8	10	0	27	0	0	0	0	0	0	0	11.4	0	0
2025	10	27	8	20	0	27	0	0	0	0	0	0	0	11.38	0	0
2025	10	27	8	30	0	27	0	0	0	0	0	0	0	11.38	0	0
2025	10	27	8	40	0	27	0	0	0	0	0	0	0	11.38	0	0
2025	10	27	8	50	0	26	0	0	0	0	0	0	0	11.38	0	0
2025	10	27	9	0	0	27	0	0	0	0	0	0	0	11.39	0	0
2025	10	27	9	10	0	27	0	0	0	0	0	0	0	11.42	0	0
2025	10	27	9	20	0	27	0	0	0	0	0	0	0	11.43	0	0
2025	10	27	9	30	0	27	0	0	0	0	0	0	0	11.45	0	0
2025	10	27	9	40	0	27	0	0	0	0	0	0	0	11.48	0	0
2025	10	27	9	50	0	26	0	0	0	0	0	0	0	11.51	0	0
2025	10	27	10	0	0	27	0	0	0	0	0	0	0	11.55	0	0
2025	10	27	10	10	0	27	0	0	0	0	0	0	0	11.6	0	0
2025	10	27	10	20	0	28	0	0	0	0	0	0	0	11.64	0	0
2025	10	27	10	30	0	27	0	0	0	0	0	0	0	11.69	0	0
2025	10	27	10	40	0	27	0	0	0	0	0	0	0	11.74	0	0
2025	10	27	10	50	0	26	0	0	0	0	0	0	0	11.8	0	0
2025	10	27	11	0	0	27	0	0	0	0	0	0	0	11.86	0	0
2025	10	27	11	10	0	27	0	0	0	0	0	0	0	11.92	0	0
2025	10	27	11	20	0	27	0	0	0	0	0	0	0	11.98	0	0
2025	10	27	11	30	0	27	0	0	0	0	0	0	0	12.05	0	0
2025	10	27	11	40	0	27	0	0	0	0	0	0	0	12.12	0	0
2025	10	27	11	50	0	27	0	0	0	0	0	0	0	12.18	0	0
2025	10	27	12	0	0	27	0	0	0	0	0	0	0	12.25	0	0
2025	10	27	12	10	0	27	0	0	0	0	0	0	0	12.33	0	0
2025	10	27	12	20	0	27	0	0	0	0	0	0	0	12.4	0	0
2025	10	27	12	30	0	26	0	0	0	0	0	0	0	12.47	0	0
2025	10	27	12	40	0	27	0	0	0	0	0	0	0	12.54	0	0
2025	10	27	12	50	0	26	0	0	0	0	0	0	0	12.62	0	0
2025	10	27	13	0	0	27	0	0	0	0	0	0	0	12.68	0	0
2025	10	27	13	10	0	27	0	0	0	0	0	0	0	12.75	0	0
2025	10	27	13	20	0	27	0	0	0	0	0	0	0	12.8	0	0
2025	10	27	13	30	0	27	0	0	0	0	0	0	0	12.87	0	0
2025	10	27	13	40	0	26	0	0	0	0	0	0	0	12.93	0	0
2025	10	27	13	50	0	26	0	0	0	0	0	0	0	13	0	0
2025	10	27	14	0	0	27	0	0	0	0	0	0	0	13.05	0	0
2025	10	27	14	10	0	27	0	0	0	0	0	0	0	13.11	0	0
2025	10	27	14	20	0	28	0	0	0	0	0	0	0	13.16	0	0
2025	10	27	14	30	0	26	0	0	0	0	0	0	0	13.21	0	0
2025	10	27	14	40	0	27	0	0	0	0	0	0	0	13.26	0	0
2025	10	27	14	50	0	27	0	0	0	0	0	0	0	13.31	0	0
2025	10	27	15	0	0	27	0	0	0	0	0	0	0	13.35	0	0
2025	10	27	15	10	0	27	0	0	0	0	0	0	0	13.39	0	0
2025	10	27	15	20	0	27	0	0	0	0	0	0	0	13.43	0	0
2025	10	27	15	30	0	27	0	0	0	0	0	0	0	13.47	0	0
2025	10	27	15	40	0	27	0	0	0	0	0	0	0	13.5	0	0
2025	10	27	15	50	0	27	0	0	0	0	0	0	0	13.53	0	0
2025	10	27	16	0	0	26	0	0	0	0	0	0	0	13.56	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	10	27	16	10	0	27	0	0	0	0	0	0	0	13.58	0	0
	2025	10	27	16	20	0	26	0	0	0	0	0	0	0	13.6	0	0
	2025	10	27	16	30	0	27	0	0	0	0	0	0	0	13.62	0	0
	2025	10	27	16	40	0	26	0	0	0	0	0	0	0	13.64	0	0
	2025	10	27	16	50	0	27	0	0	0	0	0	0	0	13.66	0	0
	2025	10	27	17	0	0	27	0	0	0	0	0	0	0	13.68	0	0
	2025	10	27	17	10	0	27	0	0	0	0	0	0	0	13.69	0	0
	2025	10	27	17	20	0	27	0	0	0	0	0	0	0	13.7	0	0
	2025	10	27	17	30	0	26	0	0	0	0	0	0	0	13.71	0	0
	2025	10	27	17	40	0	27	0	0	0	0	0	0	0	13.71	0	0
	2025	10	27	17	50	0	26	0	0	0	0	0	0	0	13.71	0	0
	2025	10	27	18	0	0	27	0	0	0	0	0	0	0	13.71	0	0
	2025	10	27	18	10	0	27	0	0	0	0	0	0	0	13.7	0	0
	2025	10	27	18	20	0	26	0	0	0	0	0	0	0	13.69	0	0
	2025	10	27	18	30	0	26	0	0	0	0	0	0	0	13.68	0	0
	2025	10	27	18	40	0	27	0	0	0	0	0	0	0	13.66	0	0
	2025	10	27	18	50	0	27	0	0	0	0	0	0	0	13.64	0	0
	2025	10	27	19	0	0	27	0	0	0	0	0	0	0	13.62	0	0
	2025	10	27	19	10	0	26	0	0	0	0	0	0	0	13.58	0	0
	2025	10	27	19	20	0	26	0	0	0	0	0	0	0	13.55	0	0
	2025	10	27	19	30	0	26	0	0	0	0	0	0	0	13.51	0	0
	2025	10	27	19	40	0	26	0	0	0	0	0	0	0	13.48	0	0
	2025	10	27	19	50	0	27	0	0	0	0	0	0	0	13.43	0	0
	2025	10	27	20	0	0	26	0	0	0	0	0	0	0	13.39	0	0
	2025	10	27	20	10	0	27	0	0	0	0	0	0	0	13.34	0	0
	2025	10	27	20	20	0	27	0	0	0	0	0	0	0	13.3	0	0
	2025	10	27	20	30	0	27	0	0	0	0	0	0	0	13.26	0	0
	2025	10	27	20	40	0	27	0	0	0	0	0	0	0	13.21	0	0
	2025	10	27	20	50	0	27	0	0	0	0	0	0	0	13.16	0	0
	2025	10	27	21	0	0	27	0	0	0	0	0	0	0	13.12	0	0
	2025	10	27	21	10	0	27	0	0	0	0	0	0	0	13.07	0	0
	2025	10	27	21	20	0	27	0	0	0	0	0	0	0	13.03	0	0
	2025	10	27	21	30	0	27	0	0	0	0	0	0	0	12.99	0	0
	2025	10	27	21	40	0	27	0	0	0	0	0	0	0	12.95	0	0
	2025	10	27	21	50	0	26	0	0	0	0	0	0	0	12.9	0	0
	2025	10	27	22	0	0	27	0	0	0	0	0	0	0	12.86	0	0
	2025	10	27	22	10	0	27	0	0	0	0	0	0	0	12.82	0	0
	2025	10	27	22	20	0	27	0	0	0	0	0	0	0	12.78	0	0
	2025	10	27	22	30	0	27	0	0	0	0	0	0	0	12.74	0	0
	2025	10	27	22	40	0	27	0	0	0	0	0	0	0	12.7	0	0
	2025	10	27	22	50	0	27	0	0	0	0	0	0	0	12.66	0	0
	2025	10	27	23	0	0	27	0	0	0	0	0	0	0	12.62	0	0
	2025	10	27	23	10	0	26	0	0	0	0	0	0	0	12.58	0	0
	2025	10	27	23	20	0	27	0	0	0	0	0	0	0	12.54	0	0
	2025	10	27	23	30	0	27	0	0	0	0	0	0	0	12.51	0	0
	2025	10	27	23	40	0	26	0	0	0	0	0	0	0	12.47	0	0
	2025	10	27	23	50	0	27	0	0	0	0	0	0	0	12.43	0	0
	2025	10	28	0	0	0	26	0	0	0	0	0	0	0	12.4	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	28	0	10	0	26	0	0	0	0	0	0	0	12.36	0	0
2025	10	28	0	20	0	27	0	0	0	0	0	0	0	12.32	0	0
2025	10	28	0	30	0	27	0	0	0	0	0	0	0	12.28	0	0
2025	10	28	0	40	0	27	0	0	0	0	0	0	0	12.25	0	0
2025	10	28	0	50	0	26	0	0	0	0	0	0	0	12.21	0	0
2025	10	28	1	0	0	27	0	0	0	0	0	0	0	12.17	0	0
2025	10	28	1	10	0	27	0	0	0	0	0	0	0	12.15	0	0
2025	10	28	1	20	0	27	0	0	0	0	0	0	0	12.11	0	0
2025	10	28	1	30	0	26	0	0	0	0	0	0	0	12.08	0	0
2025	10	28	1	40	0	27	0	0	0	0	0	0	0	12.05	0	0
2025	10	28	1	50	0	27	0	0	0	0	0	0	0	12.02	0	0
2025	10	28	2	0	0	26	0	0	0	0	0	0	0	12	0	0
2025	10	28	2	10	0	27	0	0	0	0	0	0	0	11.98	0	0
2025	10	28	2	20	0	27	0	0	0	0	0	0	0	11.96	0	0
2025	10	28	2	30	0	27	0	0	0	0	0	0	0	11.94	0	0
2025	10	28	2	40	0	27	0	0	0	0	0	0	0	11.91	0	0
2025	10	28	2	50	0	27	0	0	0	0	0	0	0	11.9	0	0
2025	10	28	3	0	0	27	0	0	0	0	0	0	0	11.88	0	0
2025	10	28	3	10	0	27	0	0	0	0	0	0	0	11.86	0	0
2025	10	28	3	20	0	27	0	0	0	0	0	0	0	11.84	0	0
2025	10	28	3	30	0	28	0	0	0	0	0	0	0	11.82	0	0
2025	10	28	3	40	0	26	0	0	0	0	0	0	0	11.81	0	0
2025	10	28	3	50	0	27	0	0	0	0	0	0	0	11.79	0	0
2025	10	28	4	0	0	27	0	0	0	0	0	0	0	11.77	0	0
2025	10	28	4	10	0	27	0	0	0	0	0	0	0	11.75	0	0
2025	10	28	4	20	0	27	0	0	0	0	0	0	0	11.74	0	0
2025	10	28	4	30	0	27	0	0	0	0	0	0	0	11.72	0	0
2025	10	28	4	40	0	27	0	0	0	0	0	0	0	11.7	0	0
2025	10	28	4	50	0	27	0	0	0	0	0	0	0	11.68	0	0
2025	10	28	5	0	0	27	0	0	0	0	0	0	0	11.67	0	0
2025	10	28	5	10	0	27	0	0	0	0	0	0	0	11.65	0	0
2025	10	28	5	20	0	27	0	0	0	0	0	0	0	11.63	0	0
2025	10	28	5	30	0	27	0	0	0	0	0	0	0	11.61	0	0
2025	10	28	5	40	0	27	0	0	0	0	0	0	0	11.59	0	0
2025	10	28	5	50	0	27	0	0	0	0	0	0	0	11.56	0	0
2025	10	28	6	0	0	27	0	0	0	0	0	0	0	11.55	0	0
2025	10	28	6	10	0	27	0	0	0	0	0	0	0	11.53	0	0
2025	10	28	6	20	0	27	0	0	0	0	0	0	0	11.51	0	0
2025	10	28	6	30	0	27	0	0	0	0	0	0	0	11.49	0	0
2025	10	28	6	40	0	27	0	0	0	0	0	0	0	11.47	0	0
2025	10	28	6	50	0	27	0	0	0	0	0	0	0	11.45	0	0
2025	10	28	7	0	0	27	0	0	0	0	0	0	0	11.43	0	0
2025	10	28	7	10	0	27	0	0	0	0	0	0	0	11.42	0	0
2025	10	28	7	20	0	27	0	0	0	0	0	0	0	11.4	0	0
2025	10	28	7	30	0	28	0	0	0	0	0	0	0	11.38	0	0
2025	10	28	7	40	0	27	0	0	0	0	0	0	0	11.37	0	0
2025	10	28	7	50	0	27	0	0	0	0	0	0	0	11.35	0	0
2025	10	28	8	0	0	27	0	0	0	0	0	0	0	11.34	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	28	8	10	0	28	0	0	0	0	0	0	0	11.32	0	0
2025	10	28	8	20	0	27	0	0	0	0	0	0	0	11.31	0	0
2025	10	28	8	30	0	27	0	0	0	0	0	0	0	11.3	0	0
2025	10	28	8	40	0	27	0	0	0	0	0	0	0	11.3	0	0
2025	10	28	8	50	0	27	0	0	0	0	0	0	0	11.31	0	0
2025	10	28	9	0	0	27	0	0	0	0	0	0	0	11.31	0	0
2025	10	28	9	10	0	28	0	0	0	0	0	0	0	11.33	0	0
2025	10	28	9	20	0	27	0	0	0	0	0	0	0	11.34	0	0
2025	10	28	9	30	0	27	0	0	0	0	0	0	0	11.36	0	0
2025	10	28	9	40	0	27	0	0	0	0	0	0	0	11.38	0	0
2025	10	28	9	50	0	27	0	0	0	0	0	0	0	11.42	0	0
2025	10	28	10	0	0	27	0	0	0	0	0	0	0	11.46	0	0
2025	10	28	10	10	0	27	0	0	0	0	0	0	0	11.49	0	0
2025	10	28	10	20	0	27	0	0	0	0	0	0	0	11.53	0	0
2025	10	28	10	30	0	28	0	0	0	0	0	0	0	11.58	0	0
2025	10	28	10	40	0	27	0	0	0	0	0	0	0	11.62	0	0
2025	10	28	10	50	0	27	0	0	0	0	0	0	0	11.68	0	0
2025	10	28	11	0	0	26	0	0	0	0	0	0	0	11.73	0	0
2025	10	28	11	10	0	27	0	0	0	0	0	0	0	11.79	0	0
2025	10	28	11	20	0	27	0	0	0	0	0	0	0	11.85	0	0
2025	10	28	11	30	0	27	0	0	0	0	0	0	0	11.91	0	0
2025	10	28	11	40	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	10	28	11	50	0	27	0	0	0	0	0	0	0	12.03	0	0
2025	10	28	12	0	0	27	0	0	0	0	0	0	0	12.1	0	0
2025	10	28	12	10	0	27	0	0	0	0	0	0	0	12.16	0	0
2025	10	28	12	20	0	27	0	0	0	0	0	0	0	12.23	0	0
2025	10	28	12	30	0	26	0	0	0	0	0	0	0	12.3	0	0
2025	10	28	12	40	0	27	0	0	0	0	0	0	0	12.36	0	0
2025	10	28	12	50	0	26	0	0	0	0	0	0	0	12.43	0	0
2025	10	28	13	0	0	27	0	0	0	0	0	0	0	12.5	0	0
2025	10	28	13	10	0	27	0	0	0	0	0	0	0	12.56	0	0
2025	10	28	13	20	0	27	0	0	0	0	0	0	0	12.62	0	0
2025	10	28	13	30	0	27	0	0	0	0	0	0	0	12.68	0	0
2025	10	28	13	40	0	27	0	0	0	0	0	0	0	12.74	0	0
2025	10	28	13	50	0	27	0	0	0	0	0	0	0	12.8	0	0
2025	10	28	14	0	0	27	0	0	0	0	0	0	0	12.85	0	0
2025	10	28	14	10	0	27	0	0	0	0	0	0	0	12.91	0	0
2025	10	28	14	20	0	27	0	0	0	0	0	0	0	12.96	0	0
2025	10	28	14	30	0	26	0	0	0	0	0	0	0	13.01	0	0
2025	10	28	14	40	0	27	0	0	0	0	0	0	0	13.05	0	0
2025	10	28	14	50	0	27	0	0	0	0	0	0	0	13.09	0	0
2025	10	28	15	0	0	27	0	0	0	0	0	0	0	13.14	0	0
2025	10	28	15	10	0	26	0	0	0	0	0	0	0	13.18	0	0
2025	10	28	15	20	0	27	0	0	0	0	0	0	0	13.22	0	0
2025	10	28	15	30	0	28	0	0	0	0	0	0	0	13.25	0	0
2025	10	28	15	40	0	27	0	0	0	0	0	0	0	13.27	0	0
2025	10	28	15	50	0	27	0	0	0	0	0	0	0	13.3	0	0
2025	10	28	16	0	0	26	0	0	0	0	0	0	0	13.32	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	10	28	16	10	0	26	0	0	0	0	0	0	0	13.35	0	0
	2025	10	28	16	20	0	27	0	0	0	0	0	0	0	13.36	0	0
	2025	10	28	16	30	0	27	0	0	0	0	0	0	0	13.37	0	0
	2025	10	28	16	40	0	26	0	0	0	0	0	0	0	13.39	0	0
	2025	10	28	16	50	0	27	0	0	0	0	0	0	0	13.4	0	0
	2025	10	28	17	0	0	26	0	0	0	0	0	0	0	13.42	0	0
	2025	10	28	17	10	0	27	0	0	0	0	0	0	0	13.42	0	0
	2025	10	28	17	20	0	27	0	0	0	0	0	0	0	13.43	0	0
	2025	10	28	17	30	0	26	0	0	0	0	0	0	0	13.43	0	0
	2025	10	28	17	40	0	27	0	0	0	0	0	0	0	13.43	0	0
	2025	10	28	17	50	0	27	0	0	0	0	0	0	0	13.42	0	0
	2025	10	28	18	0	0	27	0	0	0	0	0	0	0	13.41	0	0
	2025	10	28	18	10	0	27	0	0	0	0	0	0	0	13.39	0	0
	2025	10	28	18	20	0	26	0	0	0	0	0	0	0	13.38	0	0
	2025	10	28	18	30	0	27	0	0	0	0	0	0	0	13.36	0	0
	2025	10	28	18	40	0	26	0	0	0	0	0	0	0	13.34	0	0
	2025	10	28	18	50	0	27	0	0	0	0	0	0	0	13.31	0	0
	2025	10	28	19	0	0	26	0	0	0	0	0	0	0	13.29	0	0
	2025	10	28	19	10	0	27	0	0	0	0	0	0	0	13.26	0	0
	2025	10	28	19	20	0	27	0	0	0	0	0	0	0	13.23	0	0
	2025	10	28	19	30	0	27	0	0	0	0	0	0	0	13.2	0	0
	2025	10	28	19	40	0	26	0	0	0	0	0	0	0	13.16	0	0
	2025	10	28	19	50	0	27	0	0	0	0	0	0	0	13.12	0	0
	2025	10	28	20	0	0	27	0	0	0	0	0	0	0	13.08	0	0
	2025	10	28	20	10	0	27	0	0	0	0	0	0	0	13.04	0	0
	2025	10	28	20	20	0	27	0	0	0	0	0	0	0	13	0	0
	2025	10	28	20	30	0	26	0	0	0	0	0	0	0	12.96	0	0
	2025	10	28	20	40	0	27	0	0	0	0	0	0	0	12.93	0	0
	2025	10	28	20	50	0	27	0	0	0	0	0	0	0	12.88	0	0
	2025	10	28	21	0	0	26	0	0	0	0	0	0	0	12.84	0	0
	2025	10	28	21	10	0	27	0	0	0	0	0	0	0	12.8	0	0
	2025	10	28	21	20	0	27	0	0	0	0	0	0	0	12.76	0	0
	2025	10	28	21	30	0	27	0	0	0	0	0	0	0	12.73	0	0
	2025	10	28	21	40	0	27	0	0	0	0	0	0	0	12.68	0	0
	2025	10	28	21	50	0	27	0	0	0	0	0	0	0	12.64	0	0
	2025	10	28	22	0	0	27	0	0	0	0	0	0	0	12.61	0	0
	2025	10	28	22	10	0	26	0	0	0	0	0	0	0	12.56	0	0
	2025	10	28	22	20	0	27	0	0	0	0	0	0	0	12.52	0	0
	2025	10	28	22	30	0	27	0	0	0	0	0	0	0	12.48	0	0
	2025	10	28	22	40	0	26	0	0	0	0	0	0	0	12.44	0	0
	2025	10	28	22	50	0	27	0	0	0	0	0	0	0	12.4	0	0
	2025	10	28	23	0	0	27	0	0	0	0	0	0	0	12.37	0	0
	2025	10	28	23	10	0	27	0	0	0	0	0	0	0	12.32	0	0
	2025	10	28	23	20	0	27	0	0	0	0	0	0	0	12.28	0	0
	2025	10	28	23	30	0	27	0	0	0	0	0	0	0	12.24	0	0
	2025	10	28	23	40	0	26	0	0	0	0	0	0	0	12.21	0	0
	2025	10	28	23	50	0	27	0	0	0	0	0	0	0	12.17	0	0
	2025	10	29	0	0	0	27	0	0	0	0	0	0	0	12.12	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	29	0	10	0	26	0	0	0	0	0	0	0	12.08	0	0
2025	10	29	0	20	0	26	0	0	0	0	0	0	0	12.04	0	0
2025	10	29	0	30	0	27	0	0	0	0	0	0	0	12	0	0
2025	10	29	0	40	0	27	0	0	0	0	0	0	0	11.95	0	0
2025	10	29	0	50	0	27	0	0	0	0	0	0	0	11.91	0	0
2025	10	29	1	0	0	27	0	0	0	0	0	0	0	11.87	0	0
2025	10	29	1	10	0	27	0	0	0	0	0	0	0	11.83	0	0
2025	10	29	1	20	0	27	0	0	0	0	0	0	0	11.8	0	0
2025	10	29	1	30	0	27	0	0	0	0	0	0	0	11.76	0	0
2025	10	29	1	40	0	27	0	0	0	0	0	0	0	11.72	0	0
2025	10	29	1	50	0	27	0	0	0	0	0	0	0	11.69	0	0
2025	10	29	2	0	0	27	0	0	0	0	0	0	0	11.65	0	0
2025	10	29	2	10	0	27	0	0	0	0	0	0	0	11.63	0	0
2025	10	29	2	20	0	27	0	0	0	0	0	0	0	11.59	0	0
2025	10	29	2	30	0	27	0	0	0	0	0	0	0	11.56	0	0
2025	10	29	2	40	0	27	0	0	0	0	0	0	0	11.54	0	0
2025	10	29	2	50	0	27	0	0	0	0	0	0	0	11.51	0	0
2025	10	29	3	0	0	27	0	0	0	0	0	0	0	11.48	0	0
2025	10	29	3	10	0	27	0	0	0	0	0	0	0	11.45	0	0
2025	10	29	3	20	0	27	0	0	0	0	0	0	0	11.42	0	0
2025	10	29	3	30	0	27	0	0	0	0	0	0	0	11.4	0	0
2025	10	29	3	40	0	27	0	0	0	0	0	0	0	11.38	0	0
2025	10	29	3	50	0	27	0	0	0	0	0	0	0	11.36	0	0
2025	10	29	4	0	0	27	0	0	0	0	0	0	0	11.33	0	0
2025	10	29	4	10	0	26	0	0	0	0	0	0	0	11.31	0	0
2025	10	29	4	20	0	27	0	0	0	0	0	0	0	11.29	0	0
2025	10	29	4	30	0	27	0	0	0	0	0	0	0	11.26	0	0
2025	10	29	4	40	0	27	0	0	0	0	0	0	0	11.24	0	0
2025	10	29	4	50	0	27	0	0	0	0	0	0	0	11.23	0	0
2025	10	29	5	0	0	26	0	0	0	0	0	0	0	11.2	0	0
2025	10	29	5	10	0	28	0	0	0	0	0	0	0	11.18	0	0
2025	10	29	5	20	0	27	0	0	0	0	0	0	0	11.17	0	0
2025	10	29	5	30	0	27	0	0	0	0	0	0	0	11.15	0	0
2025	10	29	5	40	0	27	0	0	0	0	0	0	0	11.13	0	0
2025	10	29	5	50	0	27	0	0	0	0	0	0	0	11.11	0	0
2025	10	29	6	0	0	27	0	0	0	0	0	0	0	11.09	0	0
2025	10	29	6	10	0	28	0	0	0	0	0	0	0	11.07	0	0
2025	10	29	6	20	0	27	0	0	0	0	0	0	0	11.05	0	0
2025	10	29	6	30	0	28	0	0	0	0	0	0	0	11.02	0	0
2025	10	29	6	40	0	27	0	0	0	0	0	0	0	11	0	0
2025	10	29	6	50	0	27	0	0	0	0	0	0	0	10.98	0	0
2025	10	29	7	0	0	27	0	0	0	0	0	0	0	10.96	0	0
2025	10	29	7	10	0	27	0	0	0	0	0	0	0	10.94	0	0
2025	10	29	7	20	0	27	0	0	0	0	0	0	0	10.92	0	0
2025	10	29	7	30	0	27	0	0	0	0	0	0	0	10.9	0	0
2025	10	29	7	40	0	27	0	0	0	0	0	0	0	10.88	0	0
2025	10	29	7	50	0	27	0	0	0	0	0	0	0	10.86	0	0
2025	10	29	8	0	0	27	0	0	0	0	0	0	0	10.85	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	30	8	10	0	27	0	0	0	0	0	0	0	10.62	0	0
2025	10	30	8	20	0	27	0	0	0	0	0	0	0	10.62	0	0
2025	10	30	8	30	0	27	0	0	0	0	0	0	0	10.62	0	0
2025	10	30	8	40	0	27	0	0	0	0	0	0	0	10.61	0	0
2025	10	30	8	50	0	27	0	0	0	0	0	0	0	10.63	0	0
2025	10	30	9	0	0	28	0	0	0	0	0	0	0	10.63	0	0
2025	10	30	9	10	0	27	0	0	0	0	0	0	0	10.65	0	0
2025	10	30	9	20	0	27	0	0	0	0	0	0	0	10.67	0	0
2025	10	30	9	30	0	28	0	0	0	0	0	0	0	10.7	0	0
2025	10	30	9	40	0	27	0	0	0	0	0	0	0	10.72	0	0
2025	10	30	9	50	0	27	0	0	0	0	0	0	0	10.76	0	0
2025	10	30	10	0	0	28	0	0	0	0	0	0	0	10.8	0	0
2025	10	30	10	10	0	27	0	0	0	0	0	0	0	10.84	0	0
2025	10	30	10	20	0	28	0	0	0	0	0	0	0	10.88	0	0
2025	10	30	10	30	0	27	0	0	0	0	0	0	0	10.93	0	0
2025	10	30	10	40	0	27	0	0	0	0	0	0	0	10.98	0	0
2025	10	30	10	50	0	28	0	0	0	0	0	0	0	11.04	0	0
2025	10	30	11	0	0	27	0	0	0	0	0	0	0	11.09	0	0
2025	10	30	11	10	0	27	0	0	0	0	0	0	0	11.15	0	0
2025	10	30	11	20	0	27	0	0	0	0	0	0	0	11.22	0	0
2025	10	30	11	30	0	27	0	0	0	0	0	0	0	11.28	0	0
2025	10	30	11	40	0	27	0	0	0	0	0	0	0	11.35	0	0
2025	10	30	11	50	0	28	0	0	0	0	0	0	0	11.41	0	0
2025	10	30	12	0	0	27	0	0	0	0	0	0	0	11.48	0	0
2025	10	30	12	10	0	28	0	0	0	0	0	0	0	11.55	0	0
2025	10	30	12	20	0	27	0	0	0	0	0	0	0	11.62	0	0
2025	10	30	12	30	0	27	0	0	0	0	0	0	0	11.68	0	0
2025	10	30	12	40	0	27	0	0	0	0	0	0	0	11.74	0	0
2025	10	30	12	50	0	28	0	0	0	0	0	0	0	11.81	0	0
2025	10	30	13	0	0	27	0	0	0	0	0	0	0	11.87	0	0
2025	10	30	13	10	0	27	0	0	0	0	0	0	0	11.94	0	0
2025	10	30	13	20	0	27	0	0	0	0	0	0	0	12	0	0
2025	10	30	13	30	0	27	0	0	0	0	0	0	0	12.06	0	0
2025	10	30	13	40	0	27	0	0	0	0	0	0	0	12.11	0	0
2025	10	30	13	50	0	27	0	0	0	0	0	0	0	12.17	0	0
2025	10	30	14	0	0	27	0	0	0	0	0	0	0	12.22	0	0
2025	10	30	14	10	0	27	0	0	0	0	0	0	0	12.28	0	0
2025	10	30	14	20	0	27	0	0	0	0	0	0	0	12.32	0	0
2025	10	30	14	30	0	27	0	0	0	0	0	0	0	12.37	0	0
2025	10	30	14	40	0	27	0	0	0	0	0	0	0	12.41	0	0
2025	10	30	14	50	0	27	0	0	0	0	0	0	0	12.46	0	0
2025	10	30	15	0	0	27	0	0	0	0	0	0	0	12.5	0	0
2025	10	30	15	10	0	27	0	0	0	0	0	0	0	12.53	0	0
2025	10	30	15	20	0	27	0	0	0	0	0	0	0	12.56	0	0
2025	10	30	15	30	0	27	0	0	0	0	0	0	0	12.59	0	0
2025	10	30	15	40	0	27	0	0	0	0	0	0	0	12.62	0	0
2025	10	30	15	50	0	27	0	0	0	0	0	0	0	12.63	0	0
2025	10	30	16	0	0	27	0	0	0	0	0	0	0	12.66	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	10	31	0	10	0	26	0	0	0	0	0	0	0	11.57	0	0
2025	10	31	0	20	0	27	0	0	0	0	0	0	0	11.54	0	0
2025	10	31	0	30	0	27	0	0	0	0	0	0	0	11.51	0	0
2025	10	31	0	40	0	27	0	0	0	0	0	0	0	11.47	0	0
2025	10	31	0	50	0	27	0	0	0	0	0	0	0	11.43	0	0
2025	10	31	1	0	0	28	0	0	0	0	0	0	0	11.39	0	0
2025	10	31	1	10	0	27	0	0	0	0	0	0	0	11.35	0	0
2025	10	31	1	20	0	27	0	0	0	0	0	0	0	11.32	0	0
2025	10	31	1	30	0	27	0	0	0	0	0	0	0	11.29	0	0
2025	10	31	1	40	0	27	0	0	0	0	0	0	0	11.25	0	0
2025	10	31	1	50	0	27	0	0	0	0	0	0	0	11.22	0	0
2025	10	31	2	0	0	27	0	0	0	0	0	0	0	11.19	0	0
2025	10	31	2	10	0	27	0	0	0	0	0	0	0	11.16	0	0
2025	10	31	2	20	0	27	0	0	0	0	0	0	0	11.14	0	0
2025	10	31	2	30	0	27	0	0	0	0	0	0	0	11.11	0	0
2025	10	31	2	40	0	28	0	0	0	0	0	0	0	11.09	0	0
2025	10	31	2	50	0	27	0	0	0	0	0	0	0	11.07	0	0
2025	10	31	3	0	0	27	0	0	0	0	0	0	0	11.04	0	0
2025	10	31	3	10	0	27	0	0	0	0	0	0	0	11.02	0	0
2025	10	31	3	20	0	26	0	0	0	0	0	0	0	11	0	0
2025	10	31	3	30	0	27	0	0	0	0	0	0	0	10.98	0	0
2025	10	31	3	40	0	27	0	0	0	0	0	0	0	10.96	0	0
2025	10	31	3	50	0	27	0	0	0	0	0	0	0	10.94	0	0
2025	10	31	4	0	0	27	0	0	0	0	0	0	0	10.93	0	0
2025	10	31	4	10	0	27	0	0	0	0	0	0	0	10.91	0	0
2025	10	31	4	20	0	28	0	0	0	0	0	0	0	10.9	0	0
2025	10	31	4	30	0	28	0	0	0	0	0	0	0	10.88	0	0
2025	10	31	4	40	0	27	0	0	0	0	0	0	0	10.86	0	0
2025	10	31	4	50	0	27	0	0	0	0	0	0	0	10.85	0	0
2025	10	31	5	0	0	27	0	0	0	0	0	0	0	10.84	0	0
2025	10	31	5	10	0	27	0	0	0	0	0	0	0	10.83	0	0
2025	10	31	5	20	0	27	0	0	0	0	0	0	0	10.81	0	0
2025	10	31	5	30	0	27	0	0	0	0	0	0	0	10.8	0	0
2025	10	31	5	40	0	27	0	0	0	0	0	0	0	10.78	0	0
2025	10	31	5	50	0	27	0	0	0	0	0	0	0	10.77	0	0
2025	10	31	6	0	0	27	0	0	0	0	0	0	0	10.75	0	0
2025	10	31	6	10	0	28	0	0	0	0	0	0	0	10.74	0	0
2025	10	31	6	20	0	27	0	0	0	0	0	0	0	10.72	0	0
2025	10	31	6	30	0	27	0	0	0	0	0	0	0	10.7	0	0
2025	10	31	6	40	0	27	0	0	0	0	0	0	0	10.69	0	0
2025	10	31	6	50	0	27	0	0	0	0	0	0	0	10.68	0	0
2025	10	31	7	0	0	27	0	0	0	0	0	0	0	10.66	0	0
2025	10	31	7	10	0	27	0	0	0	0	0	0	0	10.65	0	0
2025	10	31	7	20	0	27	0	0	0	0	0	0	0	10.64	0	0
2025	10	31	7	30	0	28	0	0	0	0	0	0	0	10.62	0	0
2025	10	31	7	40	0	28	0	0	0	0	0	0	0	10.61	0	0
2025	10	31	7	50	0	27	0	0	0	0	0	0	0	10.6	0	0
2025	10	31	8	0	0	28	0	0	0	0	0	0	0	10.59	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	1	0	3	31	12	0.1	1.1	33	90.7	7.147	78.5278
2025	10	1	0	13	31	12	0.1	1.1	34.45	93.2	7.147	81.8594
2025	10	1	0	23	31	12	0.1	1.1	32.65	93.2	7.153	77.6449
2025	10	1	0	33	31	12	0.1	1.1	33.82	91.9	7.153	80.503
2025	10	1	0	43	31	12	0.1	1.1	34.14	92.9	7.153	81.2176
2025	10	1	0	53	31	12	0.1	1.1	34.12	91.8	7.153	81.2176
2025	10	1	1	3	31	12	0.1	1.1	33.73	92.2	7.1591	80.3361
2025	10	1	1	13	31	12	0.1	1.1	34.73	92.5	7.153	82.6468
2025	10	1	1	23	31	12	0.1	1.1	33.25	93.1	7.1591	79.1442
2025	10	1	1	33	31	12	0.1	1.1	34.22	92.2	7.1591	81.5282
2025	10	1	1	43	31	12	0.1	1.1	33.41	91.5	7.1591	79.6211
2025	10	1	1	53	31	12	0.1	1.1	32.62	91.9	7.1591	77.714
2025	10	1	2	3	31	12	0.1	1.1	33.8	90.7	7.1591	80.5747
2025	10	1	2	13	31	12	0.1	1.1	33.64	92.7	7.1591	80.098
2025	10	1	2	23	31	12	0.1	1.1	33.41	91.4	7.1591	79.6212
2025	10	1	2	33	31	12	0.1	1.1	32.83	92.4	7.1591	78.1909
2025	10	1	2	43	31	12	0.1	1.1	32.9	90.7	7.1591	78.4293
2025	10	1	2	53	31	12	0.1	1.1	33.21	91.4	7.1591	79.1445
2025	10	1	3	3	31	12	0.1	1.1	34.92	92.1	7.1652	83.2709
2025	10	1	3	13	31	12	0.1	1.1	33.61	91.5	7.1652	80.1691
2025	10	1	3	23	31	12	0.1	1.1	33.56	93.4	7.1652	79.9305
2025	10	1	3	33	31	12	0.1	1.1	34.11	91.5	7.1652	81.3622
2025	10	1	3	43	31	12	0.1	1.1	33.74	92.9	7.1652	80.4078
2025	10	1	3	53	31	12	0.1	1.1	33.43	92.2	7.1652	79.692
2025	10	1	4	3	31	12	0.1	1.1	34.04	92.9	7.1652	81.1236
2025	10	1	4	13	31	12	0.1	1.1	33.11	91.4	7.1652	78.9763
2025	10	1	4	23	31	12	0.1	1.1	33.15	93.1	7.1713	79.0462
2025	10	1	4	33	31	12	0.1	1.1	34.03	92.4	7.1713	81.1955
2025	10	1	4	43	31	11.8	0.1	1.1	34.5	90	7.1713	82.3896
2025	10	1	4	53	31	11.8	0.1	1.1	34.49	94.2	7.1713	82.1508
2025	10	1	5	3	31	11.8	0.1	1.1	34.43	92.3	7.1713	82.1509
2025	10	1	5	13	31	11.8	0.1	1.1	34.42	92.2	7.1713	82.1509
2025	10	1	5	23	31	11.8	0.1	1.1	33.63	92.2	7.1713	80.2404
2025	10	1	5	33	31	11.8	0.1	1.1	33.33	92.2	7.1774	79.5943
2025	10	1	5	43	31	11.8	0.1	1.1	33.82	92	7.1835	80.8609
2025	10	1	5	53	31	11.8	0.1	1.1	33.96	93.4	7.1896	81.1717
2025	10	1	6	3	31	11.8	0.1	1.1	33.91	91.5	7.1896	81.1718
2025	10	1	6	13	31	11.8	0.1	1.1	32.93	92.4	7.1957	78.8468
2025	10	1	6	23	31	11.8	0.1	1.1	33.91	91.2	7.2018	81.315
2025	10	1	6	33	31	11.8	0.1	1.1	33.92	92.2	7.2018	81.315
2025	10	1	6	43	31	11.8	0.1	1.1	34.31	91.3	7.2018	82.2745
2025	10	1	6	53	31	11.8	0.1	1.1	34.22	91.8	7.2018	82.0347
2025	10	1	7	3	31	11.8	0.1	1.1	34.04	92.9	7.2079	81.6268
2025	10	1	7	13	31	11.8	0.1	1.1	33.81	91.5	7.2079	81.1467
2025	10	1	7	23	31	11.8	0.1	1.1	33.42	92.1	7.2079	80.1864
2025	10	1	7	33	31	11.8	0.1	1.1	33.84	92.7	7.2079	81.1467
2025	10	1	7	43	31	12.2	0.1	1.1	33.92	92.2	7.2079	81.3869
2025	10	1	7	53	31	12.4	0.1	1.1	34.11	91.3	7.2079	81.867

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	1	8	3	31	12.6	0.1	1.1	34.16	93.4	7.2079	81.8671
2025	10	1	8	13	31	12.8	0.1	1.1	33.82	92	7.214	81.2182
2025	10	1	8	23	31	12.8	0.1	1.1	34	90	7.214	81.6988
2025	10	1	8	33	31	12.8	0.1	1.1	33.21	91.4	7.214	79.7765
2025	10	1	8	43	31	12.8	0.1	1.1	34.54	92.8	7.214	82.9003
2025	10	1	8	53	31	12.8	0.1	1.1	34.41	91.7	7.214	82.66
2025	10	1	9	3	31	12.8	0.1	1.1	34.01	91	7.214	81.6989
2025	10	1	9	13	31	13	0.1	1.1	34.12	92.2	7.214	81.9391
2025	10	1	9	23	31	13	0.1	1.1	34.22	92.2	7.214	82.1794
2025	10	1	9	33	31	13	0.1	1.1	33.93	92.5	7.214	81.4585
2025	10	1	9	43	31	13	0.1	1.1	34.98	93.8	7.214	83.8614
2025	10	1	9	53	31	13	0.1	1.1	34.02	91.9	7.214	81.6988
2025	10	1	10	3	31	13.4	0.1	1.1	34.04	92.9	7.2201	81.7705
2025	10	1	10	13	31	13.4	0.1	1.1	33.82	92.2	7.2201	81.2895
2025	10	1	10	23	31	13.2	0.1	1.1	34.13	92.5	7.2201	82.011
2025	10	1	10	33	31	13.4	0.1	1.1	34.26	93.5	7.2201	82.2514
2025	10	1	10	43	31	13.6	0.1	1.1	33.42	92.1	7.2201	80.3274
2025	10	1	10	53	31	13.6	0.1	1.1	32.63	92.3	7.2201	78.4033
2025	10	1	11	3	31	13.6	0.1	1.1	33.64	92.9	7.2201	80.8083
2025	10	1	11	13	31	13.6	0.1	1.1	34.35	93	7.2201	82.4917
2025	10	1	11	23	31	14.2	0.1	1.1	33.14	92.8	7.2262	79.6756
2025	10	1	11	33	31	14.2	0.1	1.1	33.62	92	7.2262	80.8791
2025	10	1	11	43	31	14.2	0.1	1.1	33.92	91.9	7.2262	81.6012
2025	10	1	11	53	31	14.2	0.1	1.1	33.66	93.4	7.2262	80.879
2025	10	1	12	3	31	14.2	0.1	1.1	34.26	93.5	7.2262	82.3232
2025	10	1	12	13	31	14.2	0.1	1.1	34.25	93.2	7.2262	82.3231
2025	10	1	12	23	31	14.2	0.1	1.1	33.62	91.9	7.2262	80.8788
2025	10	1	12	33	31	14.2	0.1	1.1	34.48	94	7.2262	82.8044
2025	10	1	12	43	31	14.2	0.1	1.1	34.52	91.8	7.2262	83.045
2025	10	1	12	53	31	14.2	0.1	1.1	35.24	92.8	7.2262	84.7299
2025	10	1	13	3	31	14.2	0.1	1.1	34.48	94	7.2323	82.8768
2025	10	1	13	13	31	14.2	0.1	1.1	33.7	90.7	7.2323	81.1903
2025	10	1	13	23	31	14.2	0.1	1.1	34.01	91.2	7.2323	81.913
2025	10	1	13	33	31	14.2	0.1	1.1	33.45	93.3	7.2323	80.4674
2025	10	1	13	43	31	14.2	0.1	1.1	34.7	90.7	7.2262	83.526
2025	10	1	13	53	31	14.2	0.1	1.1	34.5	90.8	7.2262	83.0446
2025	10	1	14	3	31	14.2	0.1	1.1	33.93	92.5	7.2262	81.6003
2025	10	1	14	13	31	14.2	0.1	1.1	34.57	93.6	7.2262	83.0444
2025	10	1	14	23	31	14.2	0.1	1.1	33.35	93.3	7.2262	80.1559
2025	10	1	14	33	31	14.2	0.1	1.1	34.72	92.1	7.2262	83.5257
2025	10	1	14	43	31	14.2	0.1	1.1	33.71	91.5	7.2262	81.1186
2025	10	1	14	53	31	14.2	0.1	1.1	33.55	93.2	7.2262	80.6371
2025	10	1	15	3	31	14.2	0.1	1.1	34.04	92.9	7.2262	81.8406
2025	10	1	15	13	31	14.2	0.1	1.1	34.51	91.3	7.2262	83.0441
2025	10	1	15	23	31	13.2	0.1	1.1	34.12	92	7.2201	82.0092
2025	10	1	15	33	31	13.2	0.1	1.1	33.84	95.3	7.2262	81.1184
2025	10	1	15	43	31	13.2	0.1	1.1	34.23	92.5	7.2201	82.2497
2025	10	1	15	53	31	13.2	0.1	1.1	33.47	93.6	7.2262	80.3962

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	1	16	3	31	13.2	0.1	1.1	34.06	93.5	7.2201	81.7686
2025	10	1	16	13	31	13.2	0.1	1.1	34.11	91.7	7.2201	82.0091
2025	10	1	16	23	31	13.2	0.1	1.1	34.95	93	7.2201	83.933
2025	10	1	16	33	31	13.2	0.1	1.1	34.22	92.2	7.2201	82.2495
2025	10	1	16	43	31	13.4	0.1	1.1	34.48	93.8	7.214	82.6579
2025	10	1	16	53	31	13.4	0.1	1.1	33.51	91.4	7.2201	80.566
2025	10	1	17	3	31	13.4	0.1	1.1	33.64	92.9	7.2201	80.8065
2025	10	1	17	13	31	13.4	0.1	1.1	34.41	91.7	7.2201	82.7305
2025	10	1	17	23	31	13.4	0.1	1.1	34.34	92.8	7.214	82.4176
2025	10	1	17	33	31	13.2	0.1	1.1	35.22	92	7.2201	84.6545
2025	10	1	17	43	31	12.6	0.1	1.1	33.83	92.4	7.214	81.2162
2025	10	1	17	53	31	12.4	0.1	1.1	33.71	91	7.2201	81.0471
2025	10	1	18	3	31	12.2	0.1	1.1	34.31	91.3	7.2201	82.49
2025	10	1	18	13	31	12.2	0.1	1.1	34.26	93.5	7.2262	82.3218
2025	10	1	18	23	31	12.2	0.1	1.1	32.44	92.8	7.2262	77.9891
2025	10	1	18	33	31	12.2	0.1	1.1	33.63	92.2	7.2262	80.8776
2025	10	1	18	43	31	12.2	0.1	1.1	33.97	93.7	7.2262	81.5997
2025	10	1	18	53	31	12.2	0.1	1.1	35.13	92.3	7.2262	84.4883
2025	10	1	19	3	31	12.2	0.1	1.1	33.54	92.7	7.2262	80.6369
2025	10	1	19	13	31	12.2	0.1	1.1	33.57	93.6	7.2262	80.637
2025	10	1	19	23	31	12.2	0.1	1.1	34.35	93.2	7.2262	82.5627
2025	10	1	19	33	31	12.2	0.1	1.1	34.95	93.1	7.2262	84.0069
2025	10	1	19	43	31	12.2	0.1	1.1	34.96	93.3	7.2201	83.9332
2025	10	1	19	53	31	12.2	0.1	1.1	33.66	93.4	7.2201	80.8068
2025	10	1	20	3	31	12.2	0.1	1.1	33.6	90.9	7.2201	80.8068
2025	10	1	20	13	31	12.2	0.1	1.1	34.54	92.7	7.2201	82.9713
2025	10	1	20	23	31	12	0.1	1.1	32.52	91.9	7.2201	78.1614
2025	10	1	20	33	31	12	0.1	1.1	33.64	92.9	7.2201	80.8069
2025	10	1	20	43	31	12	0.1	1.1	34.15	93.2	7.2201	82.0094
2025	10	1	20	53	31	12	0.1	1.1	34.7	90.7	7.2201	83.4524
2025	10	1	21	3	31	12	0.1	1.1	33.93	92.5	7.2201	81.5285
2025	10	1	21	13	31	12	0.1	1.1	32.71	91.4	7.214	78.5735
2025	10	1	21	23	31	12	0.1	1.1	34.41	91.5	7.214	82.6584
2025	10	1	21	33	31	12	0.1	1.1	33.53	92.2	7.214	80.4958
2025	10	1	21	43	31	12	0.1	1.1	34.15	93.2	7.214	81.9376
2025	10	1	21	53	31	12	0.1	1.1	33.92	91.9	7.214	81.457
2025	10	1	22	3	31	12	0.1	1.1	33.64	92.9	7.214	80.7362
2025	10	1	22	13	31	12	0.1	1.1	33.51	91	7.2079	80.4252
2025	10	1	22	23	31	12	0.1	1.1	33.73	92.5	7.2079	80.9054
2025	10	1	22	33	31	12	0.1	1.1	33.9	90.7	7.2079	81.3856
2025	10	1	22	43	31	12	0.1	1.1	33.92	92.2	7.2018	81.314
2025	10	1	22	53	31	12	0.1	1.1	33.8	90.8	7.1957	81.0028
2025	10	1	23	3	31	12	0.1	1.1	34.62	91.8	7.1957	82.92
2025	10	1	23	13	31	12	0.1	1.1	33.91	91	7.1957	81.2425
2025	10	1	23	23	31	12	0.1	1.1	33.61	91	7.1957	80.5235
2025	10	1	23	33	31	12	0.1	1.1	33.94	92.9	7.1896	81.1709
2025	10	1	23	43	31	12	0.1	1.1	33.71	91.7	7.1896	80.6921
2025	10	1	23	53	31	12	0.1	1.1	34.4	94.3	7.1835	82.0563

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	2	0	3	31	12	0.1	1.1	33.75	93.1	7.1835	80.621
2025	10	2	0	13	31	12	0.1	1.1	34.21	91.5	7.1835	81.8172
2025	10	2	0	23	31	12	0.1	1.1	33.43	92.2	7.1835	79.9033
2025	10	2	0	33	31	12	0.1	1.1	34.01	91.7	7.1774	81.2669
2025	10	2	0	43	31	12	0.1	1.1	33.74	92.9	7.1774	80.5499
2025	10	2	0	53	31	12	0.1	1.1	34.75	93.1	7.1774	82.9401
2025	10	2	1	3	31	12	0.1	1.1	33.01	91.6	7.1774	78.8768
2025	10	2	1	13	31	12	0.1	1.1	33.51	91.5	7.1774	80.0719
2025	10	2	1	23	31	12	0.1	1.1	34.12	91.8	7.1774	81.5061
2025	10	2	1	33	31	12	0.1	1.1	34.4	90.7	7.1774	82.2232
2025	10	2	1	43	31	12	0.1	1.1	33.51	91.7	7.1774	80.072
2025	10	2	1	53	31	12	0.1	1.1	34.44	92.7	7.1713	82.1506
2025	10	2	2	3	31	12	0.1	1.1	33.51	91.7	7.1713	80.0013
2025	10	2	2	13	31	12	0.1	1.1	33.72	92	7.1713	80.4789
2025	10	2	2	23	31	12	0.1	1.1	33.14	92.9	7.1713	79.0461
2025	10	2	2	33	31	12	0.1	1.1	33.62	92	7.1713	80.2402
2025	10	2	2	43	31	12	0.1	1.1	34.12	91.8	7.1713	81.4343
2025	10	2	2	53	31	12	0.1	1.1	34.53	92.5	7.1652	82.3167
2025	10	2	3	3	31	12	0.1	1.1	34.31	91.7	7.1652	81.8395
2025	10	2	3	13	31	12	0.1	1.1	33.13	92.4	7.1652	78.9763
2025	10	2	3	23	31	12	0.1	1.1	34.14	92.9	7.1652	81.3623
2025	10	2	3	33	31	12	0.1	1.1	34.73	92.3	7.1652	82.794
2025	10	2	3	43	31	12	0.1	1.1	34.12	92.2	7.1652	81.3624
2025	10	2	3	53	31	12	0.1	1.1	33.51	91.2	7.1652	79.9308
2025	10	2	4	3	31	11.8	0.1	1.1	33.13	92.2	7.1652	78.9764
2025	10	2	4	13	31	11.8	0.1	1.1	34.42	91.8	7.1591	82.0056
2025	10	2	4	23	31	11.8	0.1	1.1	34.14	92.9	7.1591	81.2905
2025	10	2	4	33	31	11.8	0.1	1.1	33.66	93.4	7.1591	80.0985
2025	10	2	4	43	31	11.8	0.1	1.1	34.32	92	7.1591	81.7673
2025	10	2	4	53	31	11.8	0.1	1.1	33.65	93.1	7.1591	80.0986
2025	10	2	5	3	31	11.8	0.1	1.1	34.32	91.8	7.1591	81.7673
2025	10	2	5	13	31	11.8	0.1	1.1	34.95	93	7.1591	83.1977
2025	10	2	5	23	31	11.8	0.1	1.1	33.44	92.7	7.1591	79.6219
2025	10	2	5	33	31	11.8	0.1	1.1	33.72	91.9	7.153	80.2659
2025	10	2	5	43	31	11.8	0.1	1.1	33.9	90.7	7.153	80.7423
2025	10	2	5	53	31	11.8	0.1	1.1	34.43	92.3	7.153	81.9332
2025	10	2	6	3	31	11.8	0.1	1.1	34.21	91.3	7.153	81.4569
2025	10	2	6	13	31	11.8	0.1	1.1	33.51	91	7.153	79.7896
2025	10	2	6	23	31	11.8	0.1	1.1	33.31	91.5	7.153	79.3133
2025	10	2	6	33	31	11.8	0.1	1.1	33.37	93.6	7.153	79.3133
2025	10	2	6	43	31	11.8	0.1	1.1	33.72	91.9	7.153	80.2661
2025	10	2	6	53	31	11.8	0.1	1.1	33.81	91	7.153	80.5043
2025	10	2	7	3	31	11.8	0.1	1.1	33.12	92.1	7.153	78.8371
2025	10	2	7	13	31	11.8	0.1	1.1	33.71	91	7.147	80.195
2025	10	2	7	23	31	11.8	0.1	1.1	33.6	90.9	7.153	80.028
2025	10	2	7	33	31	11.8	0.1	1.1	34.04	92.7	7.147	80.9089
2025	10	2	7	43	31	12.2	0.1	1.1	33.84	92.9	7.147	80.433
2025	10	2	7	53	31	12.4	0.1	1.1	33.27	93.8	7.147	79.0052

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	2	8	3	31	12.6	0.1	1.1	33.52	91.9	7.147	79.7192
2025	10	2	8	13	31	12.6	0.1	1.1	34.96	93.4	7.147	83.0508
2025	10	2	8	23	31	12.8	0.1	1.1	34.93	92.5	7.147	83.0508
2025	10	2	8	33	31	12.8	0.1	1.1	33.52	91.9	7.147	79.7192
2025	10	2	8	43	31	12.8	0.1	1.1	33.61	91.4	7.147	79.9572
2025	10	2	8	53	31	12.8	0.1	1.1	32.73	92.3	7.147	77.8155
2025	10	2	9	3	31	12.8	0.1	1.1	33.22	91.9	7.1409	78.9352
2025	10	2	9	13	31	12.8	0.1	1.1	32.51	91.2	7.147	77.3395
2025	10	2	9	23	31	13	0.1	1.1	32.35	93.2	7.147	76.8636
2025	10	2	9	33	31	13	0.1	1.1	33.31	91.5	7.1409	79.1729
2025	10	2	9	43	31	13	0.1	1.1	33.83	92.5	7.147	80.433
2025	10	2	9	53	31	13	0.1	1.1	32.86	93.5	7.147	78.0533
2025	10	2	10	3	31	13.2	0.1	1.1	34.06	93.5	7.147	80.9089
2025	10	2	10	13	31	13.2	0.1	1.1	33.44	92.9	7.1409	79.4106
2025	10	2	10	23	31	13.2	0.1	1.1	33.55	93.2	7.1409	79.6483
2025	10	2	10	33	31	13.2	0.1	1.1	33.49	94.3	7.1409	79.4105
2025	10	2	10	43	31	13.2	0.1	1.1	32.33	92.3	7.1409	76.7951
2025	10	2	10	53	31	14.2	0.1	1.1	33.05	93.3	7.1409	78.4594
2025	10	2	11	3	31	14.2	0.1	1.1	33.3	94.5	7.1409	78.9348
2025	10	2	11	13	31	14	0.1	1.1	33.15	93.3	7.1409	78.697
2025	10	2	11	23	31	13.2	0.1	1.1	32.87	93.7	7.1348	77.9144
2025	10	2	11	33	31	13.2	0.1	1.1	34.21	91.5	7.1287	81.1678
2025	10	2	11	43	31	13.2	0.1	1.1	32.74	92.8	7.1348	77.6768
2025	10	2	11	53	31	13.2	0.1	1.1	33.27	93.8	7.1348	78.8644
2025	10	2	12	3	31	13.2	0.1	1.1	32.56	93.5	7.1287	77.133
2025	10	2	12	13	31	13.2	0.1	1.1	33.23	92.2	7.1287	78.7942
2025	10	2	12	23	31	13.2	0.1	1.1	32.61	91.4	7.1226	77.3014
2025	10	2	12	33	31	13.2	0.1	1.1	33.41	91.4	7.1226	79.1983
2025	10	2	12	43	31	13.2	0.1	1.1	32.53	92.6	7.1287	77.1327
2025	10	2	12	53	31	13.2	0.1	1.1	34.12	92.2	7.1226	80.858
2025	10	2	13	3	31	13.2	0.1	1.1	32.52	91.8	7.1226	77.064
2025	10	2	13	13	31	13.2	0.1	1.1	33.67	93.6	7.1226	79.6722
2025	10	2	13	23	31	13.2	0.1	1.1	32.05	93	7.1165	75.8107
2025	10	2	13	33	31	13.2	0.1	1.1	33.73	92.2	7.1165	79.8381
2025	10	2	13	43	31	13.2	0.1	1.1	33.02	91.7	7.1165	78.1796
2025	10	2	13	53	31	13.2	0.1	1.1	33.46	93.4	7.1104	79.0567
2025	10	2	14	3	31	13.2	0.1	1.1	33.51	91.4	7.1165	79.3641
2025	10	2	14	13	31	13.2	0.1	1.1	33.22	91.7	7.1165	78.6533
2025	10	2	14	23	31	13.2	0.1	1.1	33.43	92.2	7.1226	79.1976
2025	10	2	14	33	31	13.2	0.1	1.1	33.18	94	7.1165	78.4163
2025	10	2	14	43	31	13.2	0.1	1.1	33.93	92.5	7.1165	80.3115
2025	10	2	14	53	31	13.2	0.1	1.1	33.12	92.1	7.1165	78.4162
2025	10	2	15	3	31	13.2	0.1	1.1	34.02	92.2	7.1165	80.5483
2025	10	2	15	13	31	13.2	0.1	1.1	32.47	93.9	7.1104	76.6893
2025	10	2	15	23	31	13.2	0.1	1.1	33.23	92.6	7.1165	78.6529
2025	10	2	15	33	31	13.2	0.1	1.1	33.85	93.2	7.1165	80.0743
2025	10	2	15	43	31	13.2	0.1	1.1	32.83	92.4	7.1104	77.6359
2025	10	2	15	53	31	13.2	0.1	1.1	32.82	92.1	7.1104	77.6359

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	2	16	3	31	13.2	0.1	1	32.83	92.3	7.1043	77.5666
2025	10	2	16	13	31	12.6	0.1	1.1	34	94.4	7.1104	80.2395
2025	10	2	16	23	31	12.4	0.1	1	34.62	92.2	7.1043	81.8233
2025	10	2	16	33	31	12.4	0.1	1	33.4	90.9	7.1043	78.9855
2025	10	2	16	43	31	12.2	0.1	1	34.11	91.3	7.1043	80.6409
2025	10	2	16	53	31	12.2	0.1	1.1	33.71	91.5	7.1104	79.7661
2025	10	2	17	3	31	12.2	0.1	1.1	33.35	93.1	7.1104	78.8193
2025	10	2	17	13	31	12.2	0.1	1	33.33	92.2	7.1043	78.749
2025	10	2	17	23	31	12.2	0.1	1	33.23	92.2	7.1043	78.5125
2025	10	2	17	33	31	12.2	0.1	1	34.64	92.8	7.0982	81.7502
2025	10	2	17	43	31	12.2	0.1	1	32.74	92.8	7.1043	77.3301
2025	10	2	17	53	31	12.2	0.1	1	33.52	91.9	7.1043	79.222
2025	10	2	18	3	31	12.2	0.1	1	33.53	92.4	7.0982	79.1513
2025	10	2	18	13	31	12.2	0.1	1	33.05	93.3	7.1043	78.0396
2025	10	2	18	23	31	12.2	0.1	1	32.81	91.2	7.1043	77.5667
2025	10	2	18	33	31	12.2	0.1	1	33.16	93.5	7.0982	78.2063
2025	10	2	18	43	31	12.2	0.1	1	32.61	91.6	7.0982	77.0249
2025	10	2	18	53	31	12.2	0.1	1	33.13	92.6	7.0982	78.2063
2025	10	2	19	3	31	12.2	0.1	1	33.37	93.8	7.1043	78.7492
2025	10	2	19	13	31	12.2	0.1	1	33.72	92	7.0982	79.624
2025	10	2	19	23	31	12.2	0.1	1	32.32	92.1	7.0982	76.3162
2025	10	2	19	33	31	12.2	0.1	1	33.13	92.6	7.0982	78.2064
2025	10	2	19	43	31	12.2	0.1	1	34.61	91.3	7.0982	81.7505
2025	10	2	19	53	31	12.2	0.1	1	33.13	92.2	7.0982	78.2065
2025	10	2	20	3	31	12.2	0.1	1	34.05	93	7.0982	80.333
2025	10	2	20	13	31	12	0.1	1	33.55	93.2	7.0982	79.1516
2025	10	2	20	23	31	12	0.1	1	32.42	91.8	7.0982	76.5526
2025	10	2	20	33	31	12	0.1	1	32.82	91.9	7.0982	77.4977
2025	10	2	20	43	31	12	0.1	1	33.11	91	7.0921	78.1367
2025	10	2	20	53	31	12	0.1	1	32.31	91.6	7.0982	76.3164
2025	10	2	21	3	31	12	0.1	1	32.63	92.3	7.0982	77.0253
2025	10	2	21	13	31	12	0.1	1	33.84	92.9	7.0921	79.7892
2025	10	2	21	23	31	12	0.1	1	33.02	91.9	7.0921	77.9008
2025	10	2	21	33	31	12	0.1	1	34.11	91	7.0982	80.5695
2025	10	2	21	43	31	12	0.1	1	33.01	91.4	7.0921	77.9008
2025	10	2	21	53	31	12	0.1	1	33.61	91.5	7.0921	79.3172
2025	10	2	22	3	31	12	0.1	1	32.91	91.2	7.0921	77.6648
2025	10	2	22	13	31	12	0.1	1	33.27	93.8	7.0982	78.4431
2025	10	2	22	23	31	12	0.1	1	32.53	92.3	7.0982	76.7892
2025	10	2	22	33	31	12	0.1	1	33.65	93.2	7.0921	79.3173
2025	10	2	22	43	31	12	0.1	1	33.84	92.7	7.0921	79.7895
2025	10	2	22	53	31	12	0.1	1	32.51	91.2	7.0921	76.7206
2025	10	2	23	3	31	12	0.1	1	33.53	92.6	7.0921	79.0813
2025	10	2	23	13	31	12	0.1	1	32.64	93	7.0921	76.9567
2025	10	2	23	23	31	12	0.1	1	33.7	90.3	7.0921	79.5535
2025	10	2	23	33	31	12	0.1	1	32.42	91.8	7.0921	76.4846
2025	10	2	23	43	31	12	0.1	1	34.22	92	7.0921	80.7338
2025	10	2	23	53	31	12	0.1	1	33.05	93.3	7.0921	77.9011

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	3	0	3	31	12	0.1	1	32.09	94.3	7.0921	75.5405
2025	10	3	0	13	31	12	0.1	1	33.03	92.3	7.0921	77.9011
2025	10	3	0	23	31	12	0.1	1	32.33	92.3	7.0921	76.2487
2025	10	3	0	33	31	12	0.1	1	34.04	92.9	7.0921	80.2618
2025	10	3	0	43	31	12	0.1	1	33.67	93.7	7.0921	79.3175
2025	10	3	0	53	31	12	0.1	1	33.23	92.6	7.0921	78.3733
2025	10	3	1	3	31	12	0.1	1	32.95	93.1	7.0921	77.6651
2025	10	3	1	13	31	12	0.1	1	32.93	92.6	7.0921	77.6651
2025	10	3	1	23	31	12	0.1	1	33.34	92.8	7.0921	78.6094
2025	10	3	1	33	31	12	0.1	1	34.05	93	7.0921	80.2618
2025	10	3	1	43	31	12	0.1	1	32.91	91.2	7.0921	77.6651
2025	10	3	1	53	31	12	0.1	1	33.54	92.9	7.0921	79.0815
2025	10	3	2	3	31	12	0.1	1	34.22	92.2	7.0921	80.734
2025	10	3	2	13	31	12	0.1	1	34.23	92.5	7.0982	80.8062
2025	10	3	2	23	31	12	0.1	1	33.02	92.1	7.0921	77.9012
2025	10	3	2	33	31	12	0.1	1	33.14	92.8	7.0982	78.2072
2025	10	3	2	43	31	12	0.1	1	33.82	92	7.0982	79.8611
2025	10	3	2	53	31	12	0.1	1	34.04	92.9	7.0921	80.2619
2025	10	3	3	3	31	12	0.1	1	33.41	91.4	7.0982	78.916
2025	10	3	3	13	31	12	0.1	1	33.34	92.9	7.0982	78.6797
2025	10	3	3	23	31	12	0.1	1	33.23	92.6	7.0982	78.4435
2025	10	3	3	33	31	12	0.1	1	32.94	93	7.0982	77.7347
2025	10	3	3	43	31	12	0.1	1	32.91	91.6	7.0982	77.7347
2025	10	3	3	53	31	12	0.1	1	33.03	92.6	7.0982	77.971
2025	10	3	4	3	31	12	0.1	1	33.32	91.9	7.0982	78.6798
2025	10	3	4	13	31	12	0.1	1	32.11	91.6	7.0982	75.8445
2025	10	3	4	23	31	12	0.1	1	33.35	93.3	7.0982	78.6798
2025	10	3	4	33	31	12	0.1	1	34.26	93.5	7.0982	80.8063
2025	10	3	4	43	31	12	0.1	1	34.39	94.2	7.0982	81.0426
2025	10	3	4	53	31	12	0.1	1	33.53	92.2	7.0982	79.1524
2025	10	3	5	3	31	11.8	0.1	1	33.34	92.9	7.0982	78.6798
2025	10	3	5	13	31	11.8	0.1	1	33.9	90.7	7.1043	80.1691
2025	10	3	5	23	31	11.8	0.1	1	33.67	93.6	7.0982	79.3887
2025	10	3	5	33	31	11.8	0.1	1	33.24	92.9	7.1043	78.5137
2025	10	3	5	43	31	11.8	0.1	1	33.37	93.6	7.1043	78.7502
2025	10	3	5	53	31	11.8	0.1	1	33.01	91.2	7.1043	78.0407
2025	10	3	6	3	31	11.8	0.1	1	33.61	91	7.1043	79.4597
2025	10	3	6	13	31	11.8	0.1	1	33.21	91.2	7.1043	78.5137
2025	10	3	6	23	31	11.8	0.1	1	33.9	89.5	7.1043	80.1692
2025	10	3	6	33	31	11.8	0.1	1	32.4	90.5	7.1043	76.6219
2025	10	3	6	43	31	11.8	0.1	1	32.82	91.7	7.1043	77.5678
2025	10	3	6	53	31	11.8	0.1	1	33.73	92.5	7.1043	79.6962
2025	10	3	7	3	31	11.8	0.1	1.1	34.33	92.5	7.1043	81.1152
2025	10	3	7	13	31	11.8	0.1	1.1	32.7	90.9	7.1043	77.3314
2025	10	3	7	23	31	11.8	0.1	1.1	32.95	93.3	7.1043	77.8044
2025	10	3	7	33	31	11.8	0.1	1.1	31.82	92	7.1043	75.203
2025	10	3	7	43	31	12.2	0.1	1.1	33.24	92.9	7.1104	78.584
2025	10	3	7	53	31	12.4	0.1	1.1	34.2	90	7.1104	80.951

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	3	8	3	31	12.4	0.1	1.1	32.01	91.3	7.1104	75.7436
2025	10	3	8	13	31	12.6	0.1	1.1	33.77	93.6	7.1104	79.7675
2025	10	3	8	23	31	12.6	0.1	1.1	34.54	92.7	7.1104	81.6611
2025	10	3	8	33	31	12.6	0.1	1.1	33.14	92.8	7.1165	78.4173
2025	10	3	8	43	31	12.6	0.1	1.1	33.61	91.2	7.1165	79.6018
2025	10	3	8	53	31	12.8	0.1	1.1	34.12	92.2	7.1226	80.8583
2025	10	3	9	3	31	12.8	0.1	1.1	33.23	92.2	7.1165	78.6541
2025	10	3	9	13	31	12.8	0.1	1.1	33.24	92.9	7.1226	78.7242
2025	10	3	9	23	31	13	0.1	1.1	33.34	92.9	7.1165	78.891
2025	10	3	9	33	31	13.2	0.1	1.1	33	90.9	7.1226	78.2499
2025	10	3	9	43	31	14.2	0.1	1.1	33.74	92.9	7.1165	79.8386
2025	10	3	9	53	31	14.2	0.1	1.1	32.73	92.3	7.1165	77.4695
2025	10	3	10	3	31	14.2	0.1	1.1	33.65	93.1	7.1165	79.6017
2025	10	3	10	13	31	14	0.1	1.1	33.5	90.9	7.1165	79.3647
2025	10	3	10	23	31	13	0.1	1.1	33.33	92.4	7.1165	78.8909
2025	10	3	10	33	31	13.2	0.1	1.1	34.03	92.5	7.1165	80.5492
2025	10	3	10	43	31	13.2	0.1	1.1	32.47	93.9	7.1226	76.827
2025	10	3	10	53	31	13.2	0.1	1.1	33.73	92.2	7.1165	79.8384
2025	10	3	11	3	31	13.2	0.1	1.1	33.22	92.1	7.1165	78.6538
2025	10	3	11	13	31	13.2	0.1	1.1	32.83	92.4	7.1165	77.7061
2025	10	3	11	23	31	13.2	0.1	1.1	33.84	92.7	7.1165	80.0752
2025	10	3	11	33	31	13.2	0.1	1.1	33.32	91.7	7.1226	78.9609
2025	10	3	11	43	31	13.2	0.1	1.1	33.33	92.2	7.1165	78.8905
2025	10	3	11	53	31	13.2	0.1	1.1	33.73	92.5	7.1165	79.8381
2025	10	3	12	3	31	13.2	0.1	1.1	34.04	92.9	7.1165	80.5488
2025	10	3	12	13	31	13.2	0.1	1.1	33.61	91	7.1165	79.6011
2025	10	3	12	23	31	12.6	0.1	1.1	32.8	90.2	7.1165	77.7058
2025	10	3	12	33	31	12.6	0.1	1.1	33.22	91.7	7.1165	78.6535
2025	10	3	12	43	31	12.6	0.1	1.1	32.61	91.6	7.1165	77.232
2025	10	3	12	53	31	12.6	0.1	1.1	32.11	91.1	7.1165	76.0474
2025	10	3	13	3	31	12.6	0.1	1.1	33.19	94.1	7.1165	78.4165
2025	10	3	13	13	31	13.2	0.1	1.1	32.2	90.7	7.1165	76.2843
2025	10	3	13	23	31	13.6	0.1	1.1	33.23	92.2	7.1165	78.6534
2025	10	3	13	33	31	13.6	0.1	1.1	33.63	92.2	7.1165	79.601
2025	10	3	13	43	31	14.2	0.1	1.1	33.95	93	7.1165	80.3117
2025	10	3	13	53	31	13.4	0.1	1.1	31.83	92.3	7.1165	75.3366
2025	10	3	14	3	31	13.4	0.1	1.1	33.13	92.4	7.1226	78.4863
2025	10	3	14	13	31	13.4	0.1	1.1	32.69	94.2	7.1226	77.3007
2025	10	3	14	23	31	13.6	0.1	1.1	32.51	91.6	7.1226	77.0635
2025	10	3	14	33	31	13.6	0.1	1.1	32.9	90.3	7.1165	77.9425
2025	10	3	14	43	31	13.6	0.1	1.1	33.14	92.9	7.1165	78.4163
2025	10	3	14	53	31	13.6	0.1	1.1	33.94	92.9	7.1165	80.3115
2025	10	3	15	3	31	13.6	0.1	1.1	34.01	91	7.1226	80.6202
2025	10	3	15	13	31	14.2	0.1	1.1	33.23	92.2	7.1226	78.7232
2025	10	3	15	23	31	13.6	0.1	1.1	32.83	92.3	7.1165	77.7055
2025	10	3	15	33	31	13.8	0.1	1.1	33.9	90.8	7.1226	80.383
2025	10	3	15	43	31	13.2	0.1	1.1	33.62	92	7.1165	79.6007
2025	10	3	15	53	31	13	0.1	1.1	33.22	91.7	7.1165	78.6531

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	3	16	3	31	11.8	0.1	1.1	33.71	91.7	7.1226	79.9088
2025	10	3	16	13	31	14	0.1	1.1	34.84	92.8	7.1165	82.4436
2025	10	3	16	23	31	13.8	0.1	1.1	34.14	92.9	7.1165	80.7853
2025	10	3	16	33	31	13.8	0.1	1.1	34.34	92.7	7.1165	81.2591
2025	10	3	16	43	31	13.6	0.1	1.1	32.8	90	7.1226	77.7748
2025	10	3	16	53	31	12.4	0.1	1.1	34.01	91.3	7.1165	80.5485
2025	10	3	17	3	31	12.4	0.1	1.1	33.52	92.1	7.1165	79.3639
2025	10	3	17	13	31	12.2	0.1	1.1	33.22	92.1	7.1165	78.6533
2025	10	3	17	23	31	12.6	0.1	1.1	33.84	92.7	7.1165	80.0747
2025	10	3	17	33	31	13.6	0.1	1.1	33.54	92.9	7.1165	79.3641
2025	10	3	17	43	31	12.6	0.1	1.1	33.3	90.5	7.1226	78.9606
2025	10	3	17	53	31	12.2	0.1	1.1	34.42	91.8	7.1165	81.4963
2025	10	3	18	3	31	12.2	0.1	1.1	33.81	91.4	7.1226	80.1463
2025	10	3	18	13	31	12.2	0.1	1.1	33.43	92.2	7.1226	79.1979
2025	10	3	18	23	31	12.2	0.1	1.1	33.44	92.7	7.1165	79.1274
2025	10	3	18	33	31	12.2	0.1	1.1	33.8	90.7	7.1165	80.0751
2025	10	3	18	43	31	12.2	0.1	1.1	33.76	93.4	7.1165	79.8382
2025	10	3	18	53	31	12.2	0.1	1.1	33.11	91.6	7.1165	78.4168
2025	10	3	19	3	31	12.2	0.1	1.1	32.93	92.4	7.1165	77.943
2025	10	3	19	13	31	12	0.1	1.1	33.02	92.1	7.1165	78.18
2025	10	3	19	23	31	12	0.1	1.1	33.6	90	7.1226	79.6725
2025	10	3	19	33	31	12	0.1	1.1	33.23	92.2	7.1226	78.724
2025	10	3	19	43	31	12	0.1	1.1	33.51	91.2	7.1226	79.4354
2025	10	3	19	53	31	12	0.1	1.1	34.03	92.5	7.1226	80.6211
2025	10	3	20	3	31	12	0.1	1.1	33.44	92.7	7.1226	79.1984
2025	10	3	20	13	31	12	0.1	1.1	33.3	90.9	7.1226	78.9613
2025	10	3	20	23	31	12	0.1	1.1	33.92	92.2	7.1226	80.3841
2025	10	3	20	33	31	12	0.1	1.1	32.91	91.6	7.1226	78.0129
2025	10	3	20	43	31	12	0.1	1.1	33.68	93.9	7.1226	79.6728
2025	10	3	20	53	31	12	0.1	1.1	34.82	92	7.1226	82.5183
2025	10	3	21	3	31	12	0.1	1.1	32.2	90	7.1287	76.4211
2025	10	3	21	13	31	12	0.1	1.1	32.91	91.6	7.1287	78.0825
2025	10	3	21	23	31	12	0.1	1.1	33.16	93.5	7.1287	78.5572
2025	10	3	21	33	31	12	0.1	1.1	34.14	92.9	7.1287	80.9306
2025	10	3	21	43	31	12	0.1	1.1	33.17	93.6	7.1287	78.5573
2025	10	3	21	53	31	12	0.1	1.1	32.64	93	7.1287	77.3707
2025	10	3	22	3	31	12	0.1	1.1	33.45	93.3	7.1287	79.2694
2025	10	3	22	13	31	12	0.1	1.1	34.27	93.7	7.1287	81.1681
2025	10	3	22	23	31	12	0.1	1.1	32.73	92.5	7.1287	77.6081
2025	10	3	22	33	31	12	0.1	1.1	33.31	91.5	7.1287	79.0321
2025	10	3	22	43	31	12	0.1	1.1	32.94	93	7.1287	78.0828
2025	10	3	22	53	31	12	0.1	1.1	33.24	92.9	7.1287	78.7948
2025	10	3	23	3	31	12	0.1	1.1	33.85	93	7.1287	80.2189
2025	10	3	23	13	31	12	0.1	1.1	33.74	92.7	7.1287	79.9816
2025	10	3	23	23	31	12	0.1	1.1	33.52	91.9	7.1287	79.5069
2025	10	3	23	33	31	12	0.1	1.1	32.12	91.8	7.1287	76.1843
2025	10	3	23	43	31	12	0.1	1.1	33.83	92.4	7.1287	80.219
2025	10	3	23	53	31	12	0.1	1.1	32.94	92.8	7.1287	78.083

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	4	0	3	31	12	0.1	1.1	32.65	93.2	7.1287	77.371
2025	10	4	0	13	31	12	0.1	1.1	31.74	92.9	7.1287	75.2351
2025	10	4	0	23	31	12	0.1	1.1	34.52	92	7.1348	81.9533
2025	10	4	0	33	31	12	0.1	1.1	32.45	93.2	7.1287	76.8965
2025	10	4	0	43	31	12	0.1	1.1	32.9	90.3	7.1287	78.0832
2025	10	4	0	53	31	12	0.1	1.1	32.92	92.1	7.1287	78.0832
2025	10	4	1	3	31	12	0.1	1.1	32.4	90	7.1287	76.8966
2025	10	4	1	13	31	12	0.1	1.1	33.5	90.7	7.1348	79.578
2025	10	4	1	23	31	12	0.1	1.1	34.37	93.7	7.1287	81.406
2025	10	4	1	33	31	12	0.1	1.1	33.04	92.8	7.1348	78.3903
2025	10	4	1	43	31	12	0.1	1.1	33.55	93.2	7.1348	79.5781
2025	10	4	1	53	31	12	0.1	1.1	33.14	92.8	7.1287	78.558
2025	10	4	2	3	31	12	0.1	1.1	33.95	93	7.1287	80.4567
2025	10	4	2	13	31	12	0.1	1.1	33.33	92.4	7.1348	79.103
2025	10	4	2	23	31	12	0.1	1.1	33.64	92.7	7.1348	79.8157
2025	10	4	2	33	31	12	0.1	1.1	33.46	93.4	7.1348	79.3407
2025	10	4	2	43	31	12	0.1	1.1	33.4	90.7	7.1348	79.3407
2025	10	4	2	53	31	12	0.1	1.1	33.65	93.2	7.1348	79.8158
2025	10	4	3	3	31	12	0.1	1.1	32.92	91.7	7.1348	78.153
2025	10	4	3	13	31	12	0.1	1.1	32.74	93	7.1348	77.6779
2025	10	4	3	23	31	12	0.1	1.1	32.72	92.1	7.1287	77.6089
2025	10	4	3	33	31	12	0.1	1.1	33.73	92.5	7.1287	79.9823
2025	10	4	3	43	31	12	0.1	1.1	33.76	93.4	7.1287	79.9823
2025	10	4	3	53	31	12	0.1	1.1	32.71	91.2	7.1287	77.6089
2025	10	4	4	3	31	12	0.1	1.1	33.12	91.7	7.1287	78.5583
2025	10	4	4	13	31	11.8	0.1	1.1	32.52	91.9	7.1287	77.1343
2025	10	4	4	23	31	11.8	0.1	1.1	32.77	93.7	7.1287	77.609
2025	10	4	4	33	31	11.8	0.1	1.1	33.01	91.4	7.1287	78.321
2025	10	4	4	43	31	11.8	0.1	1.1	34.65	93.1	7.1287	82.1185
2025	10	4	4	53	31	11.8	0.1	1.1	33.23	92.6	7.1287	78.7958
2025	10	4	5	3	31	11.8	0.1	1.1	32.13	92.5	7.1287	76.1851
2025	10	4	5	13	31	11.8	0.1	1.1	33.24	92.9	7.1287	78.7958
2025	10	4	5	23	31	11.8	0.1	1.1	33.53	95.1	7.1287	79.2705
2025	10	4	5	33	31	11.8	0.1	1.1	33.01	91.4	7.1287	78.3212
2025	10	4	5	43	31	11.8	0.1	1.1	33.54	92.9	7.1287	79.5079
2025	10	4	5	53	31	11.8	0.1	1.1	32.54	92.8	7.1287	77.1345
2025	10	4	6	3	31	11.8	0.1	1.1	33.43	92.4	7.1287	79.2706
2025	10	4	6	13	31	11.8	0.1	1.1	33.03	92.6	7.1287	78.3212
2025	10	4	6	23	31	11.8	0.1	1.1	33.11	91	7.1287	78.5586
2025	10	4	6	33	31	11.8	0.1	1.1	33.82	92.2	7.1287	80.22
2025	10	4	6	43	31	11.8	0.1	1.1	33.01	91	7.1287	78.3213
2025	10	4	6	53	31	11.8	0.1	1.1	33.82	91.9	7.1287	80.22
2025	10	4	7	3	31	11.8	0.1	1.1	33.81	91.7	7.1287	80.22
2025	10	4	7	13	31	11.8	0.1	1.1	32.71	91.4	7.1287	77.6093
2025	10	4	7	23	31	11.8	0.1	1.1	33.03	92.6	7.1287	78.3214
2025	10	4	7	33	31	11.8	0.1	1.1	34.13	92.4	7.1287	80.9321
2025	10	4	7	43	31	12.2	0.1	1.1	33.22	91.7	7.1287	78.7961
2025	10	4	7	53	31	12.4	0.1	1.1	32.21	91.2	7.1287	76.4227

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	4	8	3	31	12.6	0.1	1.1	34.41	91.5	7.1287	81.6442
2025	10	4	8	13	31	12.6	0.1	1.1	33.3	90	7.1287	79.0335
2025	10	4	8	23	31	12.8	0.1	1.1	33.51	91.7	7.1287	79.5082
2025	10	4	8	33	31	12.8	0.1	1.1	34.02	92.2	7.1287	80.6949
2025	10	4	8	43	31	12.8	0.1	1.1	32.94	93	7.1287	78.0842
2025	10	4	8	53	31	12.8	0.1	1.1	33.21	91.4	7.1287	78.7962
2025	10	4	9	3	31	13	0.1	1.1	32.2	94.5	7.1287	76.1855
2025	10	4	9	13	31	13	0.1	1.1	33.21	91.6	7.1287	78.7962
2025	10	4	9	23	31	13.2	0.1	1.1	33.05	93.1	7.1287	78.3215
2025	10	4	9	33	31	13.2	0.1	1.1	32.74	93	7.1287	77.6095
2025	10	4	9	43	31	13.4	0.1	1.1	32.44	93	7.1287	76.8975
2025	10	4	9	53	31	13.6	0.1	1.1	33.24	92.9	7.1287	78.7962
2025	10	4	10	3	31	13.6	0.1	1.1	32.14	92.9	7.1287	76.1855
2025	10	4	10	13	31	14	0.1	1.1	33.31	91.4	7.1287	79.0335
2025	10	4	10	23	31	14.2	0.1	1.1	34.81	91.6	7.1287	82.5935
2025	10	4	10	33	31	14.2	0.1	1.1	34.5	90.8	7.1287	81.8815
2025	10	4	10	43	31	14.2	0.1	1.1	32.93	92.4	7.1287	78.0841
2025	10	4	10	53	31	14.2	0.1	1.1	32.91	91.6	7.1287	78.084
2025	10	4	11	3	31	14	0.1	1.1	33.03	92.3	7.1287	78.3213
2025	10	4	11	13	31	13.8	0.1	1.1	33.23	92.6	7.1287	78.796
2025	10	4	11	23	31	14	0.1	1.1	34.08	93.9	7.1287	80.6946
2025	10	4	11	33	31	14	0.1	1.1	33.03	92.3	7.1287	78.3212
2025	10	4	11	43	31	13.8	0.1	1.1	33.84	92.9	7.1287	80.2199
2025	10	4	11	53	31	13.8	0.1	1.1	33.01	91.4	7.1287	78.3211
2025	10	4	12	3	31	14.2	0.1	1.1	32.73	92.6	7.1287	77.6091
2025	10	4	12	13	31	13.8	0.1	1.1	32.82	91.9	7.1287	77.8463
2025	10	4	12	23	31	14.2	0.1	1.1	32.45	93.2	7.1287	76.8969
2025	10	4	12	33	31	14.2	0.1	1.1	33.95	93.2	7.1287	80.4569
2025	10	4	12	43	31	14	0.1	1.1	33.6	90.7	7.1287	79.7449
2025	10	4	12	53	31	14	0.1	1.1	32.75	93.2	7.1287	77.6088
2025	10	4	13	3	31	13.8	0.1	1.1	32.43	92.3	7.1287	76.8967
2025	10	4	13	13	31	13.8	0.1	1.1	33.18	94	7.1287	78.558
2025	10	4	13	23	31	14.2	0.1	1.1	32.57	93.7	7.1287	77.1339
2025	10	4	13	33	31	14.2	0.1	1.1	32.94	93	7.1287	78.0832
2025	10	4	13	43	31	14.2	0.1	1.1	33.13	92.6	7.1287	78.5578
2025	10	4	13	53	31	13.8	0.1	1.1	33.04	92.9	7.1287	78.3204
2025	10	4	14	3	31	14.2	0.1	1.1	33.13	92.2	7.1287	78.5577
2025	10	4	14	13	31	14.2	0.1	1.1	32.93	92.6	7.1287	78.083
2025	10	4	14	23	31	14.2	0.1	1.1	32.74	93	7.1287	77.6083
2025	10	4	14	33	31	14.2	0.1	1.1	33.08	94	7.1287	78.3202
2025	10	4	14	43	31	14.2	0.1	1.1	33.81	91.5	7.1287	80.2188
2025	10	4	14	53	31	14.2	0.1	1.1	33.79	94.2	7.1287	79.9815
2025	10	4	15	3	31	14.2	0.1	1.1	33.81	91.5	7.1287	80.2187
2025	10	4	15	13	31	14.2	0.1	1.1	32.9	94.4	7.1287	77.8454
2025	10	4	15	23	31	14.2	0.1	1.1	33.53	92.4	7.1287	79.5067
2025	10	4	15	33	31	14.2	0.1	1.1	32.82	92.1	7.1226	77.776
2025	10	4	15	43	31	14.2	0.1	1.1	32.83	92.3	7.1287	77.8453
2025	10	4	15	53	31	14.2	0.1	1.1	32.62	92.1	7.1287	77.3706

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	4	16	3	31	14.2	0.1	1.1	32.71	91.4	7.1226	77.5388
2025	10	4	16	13	31	14.2	0.1	1.1	33.57	93.6	7.1226	79.4358
2025	10	4	16	23	31	14.2	0.1	1.1	33.87	93.6	7.1226	80.1471
2025	10	4	16	33	31	14	0.1	1.1	32.22	92	7.1226	76.3532
2025	10	4	16	43	31	14	0.1	1.1	32.23	92.5	7.1226	76.3531
2025	10	4	16	53	31	13.8	0.1	1.1	34.35	93	7.1226	81.3327
2025	10	4	17	3	31	13.8	0.1	1.1	33.13	92.2	7.1165	78.4173
2025	10	4	17	13	31	13.6	0.1	1.1	33.51	91.7	7.1226	79.4357
2025	10	4	17	23	31	13.4	0.1	1.1	33.56	93.4	7.1165	79.365
2025	10	4	17	33	31	13.4	0.1	1.1	34.02	92.2	7.1226	80.6213
2025	10	4	17	43	31	12.6	0.1	1.1	33.02	92.1	7.1226	78.2501
2025	10	4	17	53	31	11.6	0.1	1.1	32.91	91.6	7.1226	78.013
2025	10	4	18	3	31	11.2	0.1	1.1	32.73	92.3	7.1226	77.5388
2025	10	4	18	13	31	11.2	0.1	1.1	33.25	93.3	7.1226	78.7244
2025	10	4	18	23	31	12.2	0.1	1.1	33.44	92.9	7.1226	79.1987
2025	10	4	18	33	31	12.2	0.1	1.1	32.86	93.5	7.1226	77.7759
2025	10	4	18	43	31	12.2	0.1	1.1	32.64	93	7.1226	77.3017
2025	10	4	18	53	31	12.2	0.1	1.1	33.31	91.5	7.1226	78.9616
2025	10	4	19	3	31	12.2	0.1	1.1	33.42	91.9	7.1287	79.2693
2025	10	4	19	13	31	12.2	0.1	1.1	33.04	92.8	7.1287	78.32
2025	10	4	19	23	31	12.2	0.1	1.1	33.72	94.8	7.1287	79.744
2025	10	4	19	33	31	12.2	0.1	1.1	33.04	92.9	7.1287	78.32
2025	10	4	19	43	31	12.2	0.1	1.1	34.33	92.5	7.1287	81.4054
2025	10	4	19	53	31	12	0.1	1.1	33.6	90.3	7.1287	79.7441
2025	10	4	20	3	31	12	0.1	1.1	32.33	92.3	7.1287	76.6588
2025	10	4	20	13	31	12	0.1	1.1	32.62	92.1	7.1287	77.3709
2025	10	4	20	23	31	12	0.1	1.1	33.35	93.1	7.1287	79.0322
2025	10	4	20	33	31	12	0.1	1.1	34.21	91.5	7.1287	81.1683
2025	10	4	20	43	31	12	0.1	1.1	34.71	91.7	7.1287	82.355
2025	10	4	20	53	31	12	0.1	1.1	33.03	92.3	7.1287	78.3204
2025	10	4	21	3	31	12	0.1	1.1	33.59	94.3	7.1287	79.5071
2025	10	4	21	13	31	12	0.1	1.1	33.21	91.2	7.1287	78.7951
2025	10	4	21	23	31	12	0.1	1.1	33.3	90.7	7.1287	79.0325
2025	10	4	21	33	31	12	0.1	1.1	33.12	92.1	7.1287	78.5579
2025	10	4	21	43	31	12	0.1	1.1	32.82	91.7	7.1226	77.7766
2025	10	4	21	53	31	12	0.1	1.1	33.62	91.9	7.1287	79.7446
2025	10	4	22	3	31	12	0.1	1.1	32.84	93	7.1287	77.846
2025	10	4	22	13	31	12	0.1	1.1	33.91	91.7	7.1287	80.4567
2025	10	4	22	23	31	12	0.1	1.1	33.33	92.2	7.1287	79.0327
2025	10	4	22	33	31	12	0.1	1.1	32.74	92.8	7.1287	77.6087
2025	10	4	22	43	31	12	0.1	1.1	33.23	92.2	7.1287	78.7954
2025	10	4	22	53	31	12	0.1	1.1	33.79	94.2	7.1287	79.9822
2025	10	4	23	3	31	12	0.1	1.1	33.31	91	7.1287	79.0329
2025	10	4	23	13	31	12	0.1	1.1	33.04	92.9	7.1287	78.3209
2025	10	4	23	23	31	12	0.1	1.1	31.4	90.9	7.1226	74.4573
2025	10	4	23	33	31	12	0.1	1.1	33.33	92.4	7.1287	79.033
2025	10	4	23	43	31	12	0.1	1.1	33.22	92.1	7.1287	78.7957
2025	10	4	23	53	31	12	0.1	1.1	33.91	91.5	7.1287	80.4571

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	5	0	3	31	12	0.1	1.1	32.4	90.7	7.1287	76.897
2025	10	5	0	13	31	12	0.1	1.1	33.65	93.2	7.1287	79.7451
2025	10	5	0	23	31	12	0.1	1.1	32.69	94.2	7.1287	77.3718
2025	10	5	0	33	31	12	0.1	1.1	33.01	91.4	7.1287	78.3212
2025	10	5	0	43	31	12	0.1	1.1	33.86	93.4	7.1287	80.2199
2025	10	5	0	53	31	12	0.1	1.1	33.22	92.1	7.1226	78.7258
2025	10	5	1	3	31	12	0.1	1.1	32.4	90.7	7.1287	76.8973
2025	10	5	1	13	31	12	0.1	1.1	33.37	93.8	7.1287	79.0333
2025	10	5	1	23	31	12	0.1	1.1	33.52	92.1	7.1287	79.508
2025	10	5	1	33	31	12	0.1	1.1	32.43	92.3	7.1287	76.8974
2025	10	5	1	43	31	12	0.1	1.1	33.34	92.9	7.1287	79.0334
2025	10	5	1	53	31	12	0.1	1.1	33.22	91.7	7.1287	78.7961
2025	10	5	2	3	31	12	0.1	1.1	33.43	92.2	7.1287	79.2708
2025	10	5	2	13	31	12	0.1	1.1	33.31	91.5	7.1287	79.0335
2025	10	5	2	23	31	11.8	0.1	1.1	32.51	91.4	7.1287	77.1348
2025	10	5	2	33	31	11.8	0.1	1.1	34.06	93.4	7.1287	80.6949
2025	10	5	2	43	31	11.8	0.1	1.1	32.91	91.6	7.1287	78.0842
2025	10	5	2	53	31	11.8	0.1	1.1	33.13	92.4	7.1287	78.5589
2025	10	5	3	3	31	11.8	0.1	1.1	32.87	93.8	7.1287	77.8469
2025	10	5	3	13	31	11.8	0.1	1.1	33.21	91.2	7.1287	78.7963
2025	10	5	3	23	31	11.8	0.1	1.1	32.52	91.8	7.1287	77.1349
2025	10	5	3	33	31	11.8	0.1	1.1	33.03	92.6	7.1287	78.3217
2025	10	5	3	43	31	11.8	0.1	1.1	33.64	92.7	7.1287	79.7457
2025	10	5	3	53	31	11.8	0.1	1.1	33.24	92.9	7.1287	78.7964
2025	10	5	4	3	31	11.8	0.1	1.1	33.22	91.9	7.1287	78.7964
2025	10	5	4	13	31	11.8	0.1	1.1	33.9	90.5	7.1287	80.4578
2025	10	5	4	23	31	11.8	0.1	1.1	33.23	92.4	7.1287	78.7965
2025	10	5	4	33	31	11.8	0.1	1.1	33.64	92.7	7.1287	79.7459
2025	10	5	4	43	31	11.8	0.1	1.1	33.61	91.4	7.1287	79.7459
2025	10	5	4	53	31	11.8	0.1	1.1	32.9	90.7	7.1287	78.0845
2025	10	5	5	3	31	11.8	0.1	1.1	33.49	94.1	7.1287	79.2713
2025	10	5	5	13	31	11.8	0.1	1.1	33.13	92.2	7.1287	78.5593
2025	10	5	5	23	31	11.8	0.1	1.1	33.32	92.1	7.1287	79.034
2025	10	5	5	33	31	11.8	0.1	1.1	33.09	94.2	7.1287	78.322
2025	10	5	5	43	31	11.8	0.1	1.1	33.53	92.6	7.1287	79.5087
2025	10	5	5	53	31	11.8	0.1	1.1	33.14	92.8	7.1287	78.5594
2025	10	5	6	3	31	11.8	0.1	1.1	34.24	92.8	7.1287	81.1702
2025	10	5	6	13	31	11.8	0.1	1.1	33.63	92.6	7.1287	79.7461
2025	10	5	6	23	31	11.8	0.1	1.1	33.74	92.7	7.1287	79.9835
2025	10	5	6	33	31	11.8	0.1	1.1	33.51	91.7	7.1287	79.5088
2025	10	5	6	43	31	11.8	0.1	1.1	33.42	91.9	7.1287	79.2715
2025	10	5	6	53	31	11.8	0.1	1.1	33.62	92	7.1348	79.8172
2025	10	5	7	3	31	11.8	0.1	1.1	33.33	92.6	7.1348	79.1046
2025	10	5	7	13	31	11.8	0.1	1.1	33.85	93	7.1348	80.2924
2025	10	5	7	23	31	11.8	0.1	1.1	34.12	91.8	7.1348	81.0051
2025	10	5	7	33	31	11.8	0.1	1.1	33.82	92.2	7.1348	80.2924
2025	10	5	7	43	31	12	0.1	1.1	33.04	92.8	7.1348	78.392
2025	10	5	7	53	31	12.4	0.1	1.1	32.97	93.7	7.1348	78.1545

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	5	8	3	31	12.6	0.1	1.1	32.97	93.7	7.1348	78.1545
2025	10	5	8	13	31	12.8	0.1	1.1	32.93	92.3	7.1409	78.224
2025	10	5	8	23	31	12.8	0.1	1.1	33.81	91.5	7.1409	80.3639
2025	10	5	8	33	31	12.8	0.1	1.1	33.34	92.8	7.147	79.2454
2025	10	5	8	43	31	12.8	0.1	1.1	33.77	93.6	7.147	80.1973
2025	10	5	8	53	31	13	0.1	1.1	33.13	92.2	7.153	78.8394
2025	10	5	9	3	31	13	0.1	1.1	33.13	92.6	7.153	78.8394
2025	10	5	9	13	31	13	0.1	1.1	33.92	92	7.153	80.7448
2025	10	5	9	23	31	13.2	0.1	1.1	34.15	93	7.1591	81.2932
2025	10	5	9	33	31	13.2	0.1	1.1	32.95	93.3	7.1591	78.4324
2025	10	5	9	43	31	13.2	0.1	1.1	34.03	92.4	7.1591	81.0547
2025	10	5	9	53	31	13.4	0.1	1.1	33.41	91.2	7.1591	79.6243
2025	10	5	10	3	31	13.4	0.1	1.1	33.17	93.6	7.1591	78.9091
2025	10	5	10	13	31	13.6	0.1	1.1	34.22	94.9	7.1591	81.293
2025	10	5	10	23	31	13.6	0.1	1.1	32.6	90.9	7.1591	77.7171
2025	10	5	10	33	31	13.6	0.1	1.1	34.24	92.8	7.1591	81.5313
2025	10	5	10	43	31	13.6	0.1	1.1	34.15	93	7.1591	81.2929
2025	10	5	10	53	31	14.2	0.1	1.1	33.03	92.4	7.1591	78.6705
2025	10	5	11	3	31	14.2	0.1	1.1	33.63	92.2	7.1591	80.1008
2025	10	5	11	13	31	14.2	0.1	1.1	33.91	94.6	7.1591	80.5776
2025	10	5	11	23	31	14.2	0.1	1.1	33.92	92.2	7.1652	80.8875
2025	10	5	11	33	31	14.2	0.1	1.1	34.16	93.4	7.1591	81.2926
2025	10	5	11	43	31	14.2	0.1	1.1	33.74	92.7	7.1591	80.339
2025	10	5	11	53	31	14.2	0.1	1.1	34.92	92.1	7.153	83.126
2025	10	5	12	3	31	14.2	0.1	1.1	34.15	93	7.1591	81.2924
2025	10	5	12	13	31	14.2	0.1	1.1	33.07	93.6	7.1591	78.67
2025	10	5	12	23	31	14.2	0.1	1.1	34.06	93.4	7.1591	81.0539
2025	10	5	12	33	31	14.2	0.1	1.1	32.66	93.3	7.153	77.6475
2025	10	5	12	43	31	14.2	0.1	1.1	34.76	93.3	7.1591	82.7225
2025	10	5	12	53	31	14.2	0.1	1.1	33.22	92.1	7.1591	79.1466
2025	10	5	13	3	31	14.2	0.1	1.1	34.14	92.7	7.1591	81.292
2025	10	5	13	13	31	14.2	0.1	1.1	33.75	93.1	7.1591	80.3384
2025	10	5	13	23	31	14.2	0.1	1.1	34.1	94.4	7.1591	81.0535
2025	10	5	13	33	31	14.2	0.1	1.1	32.71	91.4	7.1591	77.9543
2025	10	5	13	43	31	14.2	0.1	1.1	33.92	92.2	7.1591	80.815
2025	10	5	13	53	31	14.2	0.1	1.1	33.83	92.4	7.1591	80.5765
2025	10	5	14	3	31	14.2	0.1	1.1	33.53	92.4	7.1591	79.8613
2025	10	5	14	13	31	14.2	0.1	1.1	34.41	91.3	7.1591	82.0068
2025	10	5	14	23	31	14.2	0.1	1.1	33.95	93.2	7.1591	80.8147
2025	10	5	14	33	31	14.2	0.1	1.1	33.05	93.3	7.1591	78.6692
2025	10	5	14	43	31	14.2	0.1	1.1	34.56	93.5	7.1652	82.3178
2025	10	5	14	53	31	14.2	0.1	1.1	34.44	92.7	7.1591	82.0066
2025	10	5	15	3	31	14.2	0.1	1.1	33.28	94	7.1652	79.2159
2025	10	5	15	13	31	14	0.1	1.1	34.9	90.3	7.1652	83.2721
2025	10	5	15	23	31	13.2	0.1	1.1	33.73	92.5	7.1652	80.4088
2025	10	5	15	33	31	13.4	0.1	1.1	34.32	92	7.1652	81.8404
2025	10	5	15	43	31	13.2	0.1	1.1	33.43	92.6	7.1652	79.693
2025	10	5	15	53	31	13.2	0.1	1.1	34.16	93.5	7.1652	81.3631

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	5	16	3	31	13.2	0.1	1.1	33.66	93.4	7.1652	80.1701
2025	10	5	16	13	31	13.2	0.1	1.1	33.66	93.4	7.1713	80.241
2025	10	5	16	23	31	13.2	0.1	1.1	33.53	92.4	7.1652	79.9314
2025	10	5	16	33	31	13.4	0.1	1.1	32.32	91.8	7.1652	77.0682
2025	10	5	16	43	31	13.4	0.1	1.1	32.83	92.6	7.1713	78.3305
2025	10	5	16	53	31	13.2	0.1	1.1	33.91	91.4	7.1713	80.9574
2025	10	5	17	3	31	13.2	0.1	1.1	33.37	93.6	7.1713	79.5245
2025	10	5	17	13	31	13.2	0.1	1.1	34.57	93.6	7.1713	82.3902
2025	10	5	17	23	31	13.4	0.1	1.1	34.2	90.8	7.1713	81.6738
2025	10	5	17	33	31	13.2	0.1	1.1	33.77	93.7	7.1774	80.5509
2025	10	5	17	43	31	12.4	0.1	1.1	34.24	92.7	7.1713	81.6738
2025	10	5	17	53	31	12.2	0.1	1.1	33.53	92.2	7.1774	80.0729
2025	10	5	18	3	31	12.2	0.1	1.1	33.85	93.2	7.1774	80.7899
2025	10	5	18	13	31	12.2	0.1	1.1	33.81	91.5	7.1835	80.8613
2025	10	5	18	23	31	12.2	0.1	1.1	33.82	92.2	7.1835	80.8614
2025	10	5	18	33	31	12.2	0.1	1.1	34.45	93	7.1835	82.2968
2025	10	5	18	43	31	12.2	0.1	1.1	34.21	91.3	7.1896	81.8905
2025	10	5	18	53	31	12.2	0.1	1.1	34.3	90.5	7.1896	82.13
2025	10	5	19	3	31	12.2	0.1	1.1	33.43	92.2	7.1896	79.975
2025	10	5	19	13	31	12.2	0.1	1.1	33.41	91.2	7.1896	79.975
2025	10	5	19	23	31	12.2	0.1	1.1	33.95	93	7.1896	81.1723
2025	10	5	19	33	31	12.2	0.1	1.1	33.95	93	7.1957	81.2439
2025	10	5	19	43	31	12.2	0.1	1.1	33.24	92.9	7.1957	79.5663
2025	10	5	19	53	31	12.2	0.1	1.1	32.81	91.4	7.1896	78.5385
2025	10	5	20	3	31	12.2	0.1	1.1	34.13	92.4	7.1957	81.7233
2025	10	5	20	13	31	12.2	0.1	1.1	33.63	92.4	7.1957	80.5251
2025	10	5	20	23	31	12	0.1	1.1	34.17	93.7	7.1957	81.7234
2025	10	5	20	33	31	12	0.1	1.1	33.45	93.1	7.1957	80.0458
2025	10	5	20	43	31	12	0.1	1.1	34.21	91.3	7.1957	81.9631
2025	10	5	20	53	31	12	0.1	1.1	34.41	91.7	7.1957	82.4424
2025	10	5	21	3	31	12	0.1	1.1	34.02	91.9	7.1957	81.4838
2025	10	5	21	13	31	12	0.1	1.1	33.65	93.1	7.1957	80.5252
2025	10	5	21	23	31	12	0.1	1.1	32.34	92.8	7.1957	77.4096
2025	10	5	21	33	31	12	0.1	1.1	33.22	91.7	7.1957	79.5666
2025	10	5	21	43	31	12	0.1	1.1	34.9	94.4	7.1957	83.4011
2025	10	5	21	53	31	12	0.1	1.1	34.02	92	7.1957	81.4839
2025	10	5	22	3	31	12	0.1	1.1	34.32	92	7.1957	82.2029
2025	10	5	22	13	31	12	0.1	1.1	33.75	93.1	7.1957	80.765
2025	10	5	22	23	31	12	0.1	1.1	34.83	92.3	7.1957	83.4012
2025	10	5	22	33	31	12	0.1	1.1	33.64	92.7	7.1957	80.5254
2025	10	5	22	43	31	12	0.1	1.1	33.73	92.5	7.1957	80.765
2025	10	5	22	53	31	12	0.1	1.1	33.03	92.3	7.1957	79.0874
2025	10	5	23	3	31	12	0.1	1.1	33.52	92.1	7.1957	80.2858
2025	10	5	23	13	31	12	0.1	1.1	34.26	93.3	7.1957	81.9634
2025	10	5	23	23	31	12	0.1	1.1	33.54	92.9	7.2018	80.3565
2025	10	5	23	33	31	12	0.1	1.1	34.39	94.2	7.2018	82.2755
2025	10	5	23	43	31	12	0.1	1.1	33.17	93.6	7.1957	79.3272
2025	10	5	23	53	31	12	0.1	1.1	33.44	92.9	7.1957	80.0462

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	6	0	3	31	12	0.1	1.1	34.76	93.3	7.2018	83.2351
2025	10	6	0	13	31	12	0.1	1.1	33.32	91.9	7.2018	79.8769
2025	10	6	0	23	31	12	0.1	1.1	34.74	92.8	7.2018	83.2351
2025	10	6	0	33	31	12	0.1	1.1	34.12	91.8	7.2018	81.796
2025	10	6	0	43	31	12	0.1	1.1	32.92	92.1	7.2018	78.9175
2025	10	6	0	53	31	12	0.1	1.1	33.61	91.5	7.2018	80.5966
2025	10	6	1	3	31	12	0.1	1.1	34.32	92	7.2018	82.2757
2025	10	6	1	13	31	12	0.1	1.1	33.7	90.9	7.2018	80.8366
2025	10	6	1	23	31	12	0.1	1.1	34	90.8	7.2018	81.5562
2025	10	6	1	33	31	12	0.1	1.1	34.02	92	7.2018	81.5562
2025	10	6	1	43	31	12	0.1	1.1	34.03	92.5	7.2018	81.5562
2025	10	6	1	53	31	12	0.1	1.1	35.15	92.9	7.2018	84.1948
2025	10	6	2	3	31	12	0.1	1.1	33.21	91.2	7.2018	79.6373
2025	10	6	2	13	31	12	0.1	1.1	34.13	92.4	7.2018	81.7962
2025	10	6	2	23	31	12	0.1	1.1	33.89	94.2	7.2018	81.0765
2025	10	6	2	33	31	12	0.1	1.1	34.02	92	7.2018	81.5563
2025	10	6	2	43	31	12	0.1	1.1	34.68	93.8	7.2018	82.9956
2025	10	6	2	53	31	12	0.1	1.1	34.74	92.8	7.2018	83.2354
2025	10	6	3	3	31	12	0.1	1.1	33.82	92	7.2018	81.0766
2025	10	6	3	13	31	12	0.1	1.1	34.53	92.3	7.2018	82.7557
2025	10	6	3	23	31	12	0.1	1.1	33.23	92.6	7.2018	79.6374
2025	10	6	3	33	31	12	0.1	1.1	34.12	91.8	7.2018	81.7963
2025	10	6	3	43	31	12	0.1	1.1	34.42	91.8	7.2018	82.5159
2025	10	6	3	53	31	12	0.1	1.1	34.16	93.5	7.2018	81.7963
2025	10	6	4	3	31	11.8	0.1	1.1	34.23	92.3	7.2018	82.0362
2025	10	6	4	13	31	11.8	0.1	1.1	34.26	93.5	7.2018	82.0362
2025	10	6	4	23	31	11.8	0.1	1.1	33.83	92.5	7.2018	81.0768
2025	10	6	4	33	31	11.8	0.1	1.1	34.03	92.5	7.2018	81.5565
2025	10	6	4	43	31	11.8	0.1	1.1	33.33	92.6	7.2018	79.8774
2025	10	6	4	53	31	11.8	0.1	1.1	33.77	93.6	7.2018	80.8369
2025	10	6	5	3	31	11.8	0.1	1.1	33.88	93.9	7.2018	81.0768
2025	10	6	5	13	31	11.8	0.1	1.1	34.71	91	7.2018	83.2357
2025	10	6	5	23	31	11.8	0.1	1.1	33.85	93	7.2018	81.0769
2025	10	6	5	33	31	11.8	0.1	1.1	34.61	91.3	7.2018	82.9959
2025	10	6	5	43	31	11.8	0.1	1.1	33.53	92.6	7.2018	80.3573
2025	10	6	5	53	31	11.8	0.1	1.1	33.64	92.9	7.2018	80.5972
2025	10	6	6	3	31	11.8	0.1	1.1	33.33	92.6	7.2018	79.8776
2025	10	6	6	13	31	11.8	0.1	1.1	35	96.1	7.2018	83.4757
2025	10	6	6	23	31	11.8	0.1	1.1	33.73	92.2	7.2018	80.8371
2025	10	6	6	33	31	11.8	0.1	1.1	34.42	92.2	7.2018	82.5162
2025	10	6	6	43	31	11.8	0.1	1.1	34.02	92.2	7.2018	81.5568
2025	10	6	6	53	31	11.8	0.1	1.1	33.75	93.2	7.2018	80.8372
2025	10	6	7	3	31	11.8	0.1	1.1	35.08	93.9	7.2079	84.0294
2025	10	6	7	13	31	11.8	0.1	1.1	34.46	93.5	7.2018	82.5163
2025	10	6	7	23	31	11.8	0.1	1.1	32.9	90	7.2018	78.9182
2025	10	6	7	33	31	11.8	0.1	1.1	34.82	92.1	7.2079	83.5493
2025	10	6	7	43	31	12	0.1	1.1	33.12	91.9	7.2079	79.4679
2025	10	6	7	53	31	12.4	0.1	1.1	33.13	92.2	7.2079	79.4679

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	6	8	3	31	12.6	0.1	1.1	33.82	92.2	7.2079	81.1485
2025	10	6	8	13	31	12.8	0.1	1.1	34.26	93.5	7.2079	82.1089
2025	10	6	8	23	31	12.8	0.1	1.1	34.36	93.5	7.2079	82.349
2025	10	6	8	33	31	12.8	0.1	1.1	35.07	93.6	7.2079	84.0296
2025	10	6	8	43	31	12.8	0.1	1.1	33.93	92.5	7.2079	81.3886
2025	10	6	8	53	31	12.8	0.1	1.1	33.92	92	7.2079	81.3886
2025	10	6	9	3	31	12.8	0.1	1.1	33.94	92.7	7.2079	81.3886
2025	10	6	9	13	31	13	0.1	1.1	34.3	90.8	7.2079	82.3489
2025	10	6	9	23	31	13	0.1	1.1	33.91	91.2	7.2079	81.3886
2025	10	6	9	33	31	13	0.1	1.1	33.64	92.7	7.2079	80.6683
2025	10	6	9	43	31	13.2	0.1	1.1	33.14	92.9	7.2079	79.4679
2025	10	6	9	53	31	13.2	0.1	1.1	33.31	91.2	7.2079	79.948
2025	10	6	10	3	31	13.4	0.1	1.1	33.06	93.5	7.2079	79.2277
2025	10	6	10	13	31	13.8	0.1	1.1	33.03	92.6	7.2079	79.2277
2025	10	6	10	23	31	14.2	0.1	1.1	33.57	93.6	7.2079	80.4281
2025	10	6	10	33	31	14.2	0.1	1.1	34.52	92.2	7.2079	82.8289
2025	10	6	10	43	31	14.2	0.1	1.1	33.92	91.9	7.2079	81.3883
2025	10	6	10	53	31	14.2	0.1	1.1	33.08	94	7.2079	79.2275
2025	10	6	11	3	31	14.2	0.1	1.1	34.95	93	7.2079	83.7891
2025	10	6	11	13	31	14	0.1	1.1	34.3	90.8	7.2079	82.3485
2025	10	6	11	23	31	14	0.1	1.1	34.02	92.2	7.2079	81.6282
2025	10	6	11	33	31	14.2	0.1	1.1	33.02	92.1	7.2079	79.2273
2025	10	6	11	43	31	14.2	0.1	1.1	33.94	92.7	7.2079	81.388
2025	10	6	11	53	31	14.2	0.1	1.1	32.83	92.3	7.2079	78.747
2025	10	6	12	3	31	14.2	0.1	1.1	34.61	91.7	7.2079	83.0685
2025	10	6	12	13	31	14.2	0.1	1.1	33.62	91.9	7.2079	80.6676
2025	10	6	12	23	31	14.2	0.1	1.1	33.91	91.7	7.2079	81.3878
2025	10	6	12	33	31	14.2	0.1	1.1	34.42	91.8	7.2079	82.5881
2025	10	6	12	43	31	14.2	0.1	1.1	34.36	93.5	7.2079	82.348
2025	10	6	12	53	31	14.2	0.1	1.1	32.74	93	7.2079	78.5066
2025	10	6	13	3	31	14.2	0.1	1.1	33.31	91.4	7.2079	79.947
2025	10	6	13	13	31	14.2	0.1	1.1	34.45	93.2	7.214	82.6605
2025	10	6	13	23	31	14.2	0.1	1.1	33.53	92.4	7.214	80.4978
2025	10	6	13	33	31	14.2	0.1	1.1	33.75	93.1	7.214	80.9783
2025	10	6	13	43	31	14.2	0.1	1.1	33.33	92.2	7.214	80.0171
2025	10	6	13	53	31	14.2	0.1	1.1	33.81	91.5	7.214	81.2185
2025	10	6	14	3	31	14.2	0.1	1.1	34.15	93.2	7.214	81.9393
2025	10	6	14	13	31	14.2	0.1	1.1	33.87	93.6	7.214	81.2183
2025	10	6	14	23	31	14.2	0.1	1.1	33.81	91.5	7.214	81.2183
2025	10	6	14	33	31	14.2	0.1	1.1	34.28	93.8	7.214	82.1794
2025	10	6	14	43	31	14.2	0.1	1.1	34.21	91.3	7.214	82.1793
2025	10	6	14	53	31	14.2	0.1	1.1	33.82	92	7.214	81.2181
2025	10	6	15	3	31	14.2	0.1	1.1	33.43	92.2	7.214	80.2569
2025	10	6	15	13	31	14	0.1	1.1	33.33	92.2	7.2201	80.0869
2025	10	6	15	23	31	14	0.1	1.1	34.01	91.5	7.214	81.6986
2025	10	6	15	33	31	14	0.1	1.1	33.44	92.9	7.214	80.2568
2025	10	6	15	43	31	14	0.1	1.1	34.33	92.5	7.214	82.4194
2025	10	6	15	53	31	14	0.1	1.1	33.57	93.8	7.214	80.497

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	6	16	3	31	13.8	0.1	1.1	35.12	92	7.214	84.3416
2025	10	6	16	13	31	13.6	0.1	1.1	33.13	92.4	7.214	79.5358
2025	10	6	16	23	31	13.4	0.1	1.1	34.41	91.5	7.214	82.6595
2025	10	6	16	33	31	13.4	0.1	1.1	34.21	94.7	7.214	81.9387
2025	10	6	16	43	31	13.4	0.1	1.1	34.74	92.6	7.2201	83.4537
2025	10	6	16	53	31	13.4	0.1	1.1	33.15	93.1	7.2201	79.6056
2025	10	6	17	3	31	13.4	0.1	1.1	33.27	93.6	7.214	79.776
2025	10	6	17	13	31	13.2	0.1	1.1	33.64	92.9	7.2201	80.8081
2025	10	6	17	23	31	13.2	0.1	1.1	33.95	93.2	7.2201	81.5296
2025	10	6	17	33	31	12.8	0.1	1.1	32.63	92.3	7.2201	78.4031
2025	10	6	17	43	31	12.4	0.1	1.1	33.82	92.2	7.2201	81.2891
2025	10	6	17	53	31	11.4	0.1	1.1	34.21	91.5	7.2201	82.2512
2025	10	6	18	3	31	11.8	0.1	1.1	34.36	93.5	7.2201	82.4917
2025	10	6	18	13	31	11.8	0.1	1.1	33.52	92.1	7.2201	80.5677
2025	10	6	18	23	31	12.2	0.1	1.1	33.53	92.6	7.2201	80.5677
2025	10	6	18	33	31	12.2	0.1	1.1	32.94	92.8	7.2201	79.1247
2025	10	6	18	43	31	11.6	0.1	1.1	33.61	91.7	7.2201	80.8082
2025	10	6	18	53	31	11.6	0.1	1.1	34.18	93.9	7.2201	82.0107
2025	10	6	19	3	31	11.6	0.1	1.1	33.59	94.1	7.2201	80.5678
2025	10	6	19	13	31	11.6	0.1	1.1	33.92	92.2	7.2201	81.5298
2025	10	6	19	23	31	12.2	0.1	1.1	34.55	93.2	7.2201	82.9729
2025	10	6	19	33	31	12.2	0.1	1.1	34.01	91.5	7.2201	81.7704
2025	10	6	19	43	31	12	0.1	1.1	34.11	91.2	7.2201	82.0109
2025	10	6	19	53	31	12	0.1	1.1	33.92	92	7.2201	81.53
2025	10	6	20	3	31	12	0.1	1.1	34.28	94	7.2201	82.2515
2025	10	6	20	13	31	12	0.1	1.1	34.54	92.7	7.2201	82.973
2025	10	6	20	23	31	12	0.1	1.1	33.24	92.9	7.214	79.7764
2025	10	6	20	33	31	12	0.1	1.1	33.5	89.8	7.214	80.4973
2025	10	6	20	43	31	12	0.1	1.1	33.63	92.6	7.214	80.7377
2025	10	6	20	53	31	12	0.1	1.1	33.84	92.9	7.214	81.2183
2025	10	6	21	3	31	12	0.1	1.1	32.92	91.9	7.214	79.0557
2025	10	6	21	13	31	12	0.1	1.1	33.91	91.4	7.214	81.4586
2025	10	6	21	23	31	12	0.1	1.1	33.92	92	7.214	81.4587
2025	10	6	21	33	31	12	0.1	1.1	34.4	90.8	7.214	82.6602
2025	10	6	21	43	31	12	0.1	1.1	34.43	92.5	7.214	82.6602
2025	10	6	21	53	31	12	0.1	1.1	34.14	92.9	7.214	81.9394
2025	10	6	22	3	31	12	0.1	1.1	34.81	91.5	7.214	83.6214
2025	10	6	22	13	31	12	0.1	1.1	34.88	93.8	7.214	83.6215
2025	10	6	22	23	31	12	0.1	1.1	34.51	91.3	7.214	82.9006
2025	10	6	22	33	31	12	0.1	1.1	33.24	92.9	7.214	79.7769
2025	10	6	22	43	31	12	0.1	1.1	33.2	90.7	7.214	79.7769
2025	10	6	22	53	31	12	0.1	1.1	33.51	91.5	7.214	80.4978
2025	10	6	23	3	31	12	0.1	1.1	33.61	91	7.2079	80.6672
2025	10	6	23	13	31	12	0.1	1.1	33.82	91.9	7.214	81.2187
2025	10	6	23	23	31	12	0.1	1.1	34.01	91.7	7.2079	81.6276
2025	10	6	23	33	31	12	0.1	1.1	33.9	90.7	7.2079	81.3875
2025	10	6	23	43	31	12	0.1	1.1	34.34	92.8	7.2079	82.3479
2025	10	6	23	53	31	12	0.1	1.1	33.61	91.4	7.2079	80.6673

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	7	0	3	31	12	0.1	1.1	33.54	92.7	7.2079	80.4273
2025	10	7	0	13	31	12	0.1	1.1	34.11	91.5	7.2079	81.8678
2025	10	7	0	23	31	12	0.1	1.1	33.01	91.6	7.2079	79.2269
2025	10	7	0	33	31	12	0.1	1.1	33	90.9	7.2079	79.2269
2025	10	7	0	43	31	12	0.1	1.1	34.33	92.3	7.2079	82.348
2025	10	7	0	53	31	12	0.1	1.1	34.3	90	7.2079	82.3481
2025	10	7	1	3	31	12	0.1	1.1	34.47	93.7	7.2079	82.5882
2025	10	7	1	13	31	12	0.1	1.1	32.81	91	7.2079	78.7469
2025	10	7	1	23	31	12	0.1	1.1	34.11	91.5	7.2079	81.868
2025	10	7	1	33	31	12	0.1	1.1	34.12	91.8	7.2079	81.868
2025	10	7	1	43	31	12	0.1	1.1	33.71	91.7	7.2079	80.9077
2025	10	7	1	53	31	12	0.1	1.1	33.52	92.1	7.2079	80.4276
2025	10	7	2	3	31	12	0.1	1.1	34.55	93	7.2079	82.8284
2025	10	7	2	13	31	12	0.1	1.1	34.04	92.9	7.2018	81.5562
2025	10	7	2	23	31	12	0.1	1.1	33.53	92.6	7.2079	80.4276
2025	10	7	2	33	31	12	0.1	1.1	32.9	90.5	7.2018	78.9177
2025	10	7	2	43	31	12	0.1	1.1	33.35	93.1	7.2018	79.8772
2025	10	7	2	53	31	12	0.1	1.1	34.21	91	7.2018	82.0361
2025	10	7	3	3	31	11.8	0.1	1.1	35.28	93.9	7.2018	84.4348
2025	10	7	3	13	31	11.8	0.1	1.1	33.92	92.2	7.2018	81.3165
2025	10	7	3	23	31	11.8	0.1	1.1	35.47	93.6	7.2018	84.9146
2025	10	7	3	33	31	11.8	0.1	1.1	34.04	92.9	7.2018	81.5564
2025	10	7	3	43	31	11.8	0.1	1.1	34.14	92.9	7.2018	81.7963
2025	10	7	3	53	31	11.8	0.1	1.1	34.54	92.8	7.2018	82.7558
2025	10	7	4	3	31	11.8	0.1	1.1	34.5	90.7	7.2018	82.7558
2025	10	7	4	13	31	11.8	0.1	1.1	34.27	93.7	7.2018	82.0363
2025	10	7	4	23	31	11.8	0.1	1.1	33.49	94.1	7.2018	80.1173
2025	10	7	4	33	31	11.8	0.1	1.1	34.44	92.7	7.2018	82.5161
2025	10	7	4	43	31	11.8	0.1	1.1	34.06	93.5	7.2018	81.5566
2025	10	7	4	53	31	11.8	0.1	1.1	35.08	93.9	7.2018	83.9553
2025	10	7	5	3	31	11.8	0.1	1.1	33.68	93.9	7.2018	80.5971
2025	10	7	5	13	31	11.8	0.1	1.1	34.23	92.3	7.2018	82.0364
2025	10	7	5	23	31	11.8	0.1	1.1	33.85	93	7.2018	81.0769
2025	10	7	5	33	31	11.8	0.1	1.1	35.11	91.1	7.2018	84.1953
2025	10	7	5	43	31	11.8	0.1	1.1	34.04	92.9	7.2018	81.5567
2025	10	7	5	53	31	11.8	0.1	1.1	33.95	93.2	7.2018	81.3169
2025	10	7	6	3	31	11.8	0.1	1.1	34.54	92.8	7.2018	82.7561
2025	10	7	6	13	31	11.8	0.1	1.1	34.56	93.3	7.2018	82.7561
2025	10	7	6	23	31	11.8	0.1	1.1	33.11	91	7.2018	79.3979
2025	10	7	6	33	31	11.8	0.1	1.1	34.12	94.9	7.2018	81.5568
2025	10	7	6	43	31	11.8	0.1	1.1	34.32	92	7.2018	82.2764
2025	10	7	6	53	31	11.8	0.1	1.1	34.05	93.2	7.2018	81.5569
2025	10	7	7	3	31	11.8	0.1	1.1	34.04	92.9	7.2018	81.5569
2025	10	7	7	13	31	11.8	0.1	1.1	33.51	91.5	7.2018	80.3575
2025	10	7	7	23	31	11.8	0.1	1.1	34.16	93.4	7.2018	81.7968
2025	10	7	7	33	31	11.8	0.1	1.1	33.54	92.9	7.2018	80.3576
2025	10	7	7	43	31	12	0.1	1.1	33.5	90	7.2018	80.3576
2025	10	7	7	53	31	12.4	0.1	1.1	33.31	91.2	7.2018	79.8778

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	7	8	3	31	12.6	0.1	1.1	33.39	94.3	7.2018	79.8779
2025	10	7	8	13	31	12.8	0.1	1.1	34.12	92.2	7.2018	81.7969
2025	10	7	8	23	31	12.8	0.1	1.1	33.63	92.6	7.2018	80.5975
2025	10	7	8	33	31	13	0.1	1.1	34.25	93.2	7.2018	82.0367
2025	10	7	8	43	31	12.8	0.1	1.1	34.91	91.1	7.2018	83.7159
2025	10	7	8	53	31	13	0.1	1.1	33.54	92.9	7.2018	80.3576
2025	10	7	9	3	31	13	0.1	1.1	33.56	93.4	7.2018	80.3576
2025	10	7	9	13	31	13	0.1	1.1	34.76	93.5	7.2018	83.2361
2025	10	7	9	23	31	13	0.1	1.1	33.82	92.2	7.2018	81.0772
2025	10	7	9	33	31	13	0.1	1.1	34.56	93.3	7.2018	82.7563
2025	10	7	9	43	31	13	0.1	1.1	34.28	94	7.2018	82.0367
2025	10	7	9	53	31	13.2	0.1	1.1	33.82	92.2	7.2018	81.0771
2025	10	7	10	3	31	13.6	0.1	1.1	34.22	91.8	7.2018	82.0366
2025	10	7	10	13	31	13.4	0.1	1.1	34.04	92.9	7.2018	81.5568
2025	10	7	10	23	31	14	0.1	1.1	34.91	94.6	7.2018	83.4757
2025	10	7	10	33	31	14.2	0.1	1.1	33.95	93.2	7.2018	81.3169
2025	10	7	10	43	31	14.2	0.1	1.1	33.51	91.7	7.2018	80.3573
2025	10	7	10	53	31	14.2	0.1	1.1	33.74	92.9	7.2079	80.9082
2025	10	7	11	3	31	14.2	0.1	1.1	34.36	93.3	7.2018	82.2762
2025	10	7	11	13	31	14.2	0.1	1.1	34.14	92.9	7.2079	81.8684
2025	10	7	11	23	31	14.2	0.1	1.1	34.04	92.9	7.2079	81.6283
2025	10	7	11	33	31	14.2	0.1	1.1	33.81	91.7	7.2079	81.1481
2025	10	7	11	43	31	14.2	0.1	1.1	33.85	93	7.2079	81.148
2025	10	7	11	53	31	14.2	0.1	1.1	33.74	92.7	7.2079	80.9079
2025	10	7	12	3	31	14.2	0.1	1.1	33.94	92.7	7.2079	81.388
2025	10	7	12	13	31	14.2	0.1	1.1	34.12	92	7.2079	81.8681
2025	10	7	12	23	31	14.2	0.1	1.1	35.08	93.8	7.2079	84.0288
2025	10	7	12	33	31	14.2	0.1	1.1	33.9	94.4	7.2079	81.1477
2025	10	7	12	43	31	14.2	0.1	1.1	34.44	92.7	7.2079	82.5881
2025	10	7	12	53	31	14.2	0.1	1.1	33.43	92.2	7.2079	80.1873
2025	10	7	13	3	31	14.2	0.1	1.1	34.32	91.8	7.2079	82.3479
2025	10	7	13	13	31	14.2	0.1	1.1	34.76	93.3	7.2079	83.3082
2025	10	7	13	23	31	14.2	0.1	1.1	35.28	93.9	7.2079	84.5085
2025	10	7	13	33	31	14.2	0.1	1.1	32.71	91.6	7.2079	78.5064
2025	10	7	13	43	31	14.2	0.1	1.1	34.58	93.8	7.2079	82.8278
2025	10	7	13	53	31	14.2	0.1	1.1	34.02	92.2	7.2079	81.6274
2025	10	7	14	3	31	14.2	0.1	1.1	33.23	95	7.2079	79.4666
2025	10	7	14	13	31	14.2	0.1	1.1	34.33	92.3	7.2079	82.3475
2025	10	7	14	23	31	14.2	0.1	1.1	33.9	94.4	7.2079	81.1471
2025	10	7	14	33	31	14.2	0.1	1.1	35.42	92.1	7.214	85.063
2025	10	7	14	43	31	14.2	0.1	1.1	34.23	92.5	7.2079	82.1073
2025	10	7	14	53	31	14.2	0.1	1.1	34.12	92	7.2079	81.8672
2025	10	7	15	3	31	14.2	0.1	1.1	33.96	93.4	7.2079	81.387
2025	10	7	15	13	31	14.2	0.1	1.1	33.04	92.8	7.214	79.2959
2025	10	7	15	23	31	14.2	0.1	1.1	33.39	94.1	7.2079	79.9464
2025	10	7	15	33	31	14.2	0.1	1.1	33.5	90.7	7.2079	80.4265
2025	10	7	15	43	31	14.2	0.1	1.1	33.93	92.5	7.2079	81.3868
2025	10	7	15	53	31	14.2	0.1	1.1	34.51	91.3	7.2079	82.8272

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	7	16	3	31	14.2	0.1	1.1	33.53	92.2	7.2079	80.4264
2025	10	7	16	13	31	13.8	0.1	1.1	34.74	92.6	7.2079	83.3073
2025	10	7	16	23	31	13.8	0.1	1.1	34.34	92.7	7.2079	82.347
2025	10	7	16	33	31	13.8	0.1	1.1	34.45	93	7.2079	82.5871
2025	10	7	16	43	31	13.6	0.1	1.1	33.81	91.5	7.2079	81.1466
2025	10	7	16	53	31	13.6	0.1	1.1	34.02	92.2	7.2079	81.6267
2025	10	7	17	3	31	13.4	0.1	1.1	34.94	92.8	7.2079	83.7874
2025	10	7	17	13	31	13.2	0.1	1.1	34.76	93.5	7.2079	83.3073
2025	10	7	17	23	31	13.2	0.1	1.1	34.23	92.3	7.2079	82.1069
2025	10	7	17	33	31	12.8	0.1	1.1	33.23	92.2	7.2079	79.7061
2025	10	7	17	43	31	12.4	0.1	1.1	33.24	92.9	7.2079	79.7061
2025	10	7	17	53	31	11.8	0.1	1.1	34.02	92.2	7.2079	81.6267
2025	10	7	18	3	31	11.8	0.1	1.1	35.15	92.9	7.2079	84.2676
2025	10	7	18	13	31	11.2	0.1	1.1	35.24	92.6	7.2079	84.5077
2025	10	7	18	23	31	12.2	0.1	1.1	33.41	91.4	7.2079	80.1863
2025	10	7	18	33	31	12.2	0.1	1.1	33.41	91.2	7.2079	80.1863
2025	10	7	18	43	31	12.2	0.1	1.1	34.64	92.8	7.2079	83.0673
2025	10	7	18	53	31	12.2	0.1	1.1	33.83	92.5	7.2079	81.1467
2025	10	7	19	3	31	12.2	0.1	1.1	34.62	92.2	7.2079	83.0674
2025	10	7	19	13	31	12.2	0.1	1.1	34.03	92.4	7.2079	81.6269
2025	10	7	19	23	31	12.2	0.1	1.1	33.81	91.2	7.2079	81.1468
2025	10	7	19	33	31	12.2	0.1	1.1	34.41	91.7	7.2079	82.5873
2025	10	7	19	43	31	12.2	0.1	1.1	34.41	91.7	7.2079	82.5874
2025	10	7	19	53	31	12	0.1	1.1	33.73	92.2	7.2079	80.9069
2025	10	7	20	3	31	12	0.1	1.1	34.97	93.6	7.2079	83.7878
2025	10	7	20	13	31	12	0.1	1.1	34.01	91	7.2079	81.6272
2025	10	7	20	23	31	12	0.1	1.1	35.04	92.6	7.2079	84.028
2025	10	7	20	33	31	12	0.1	1.1	34.42	92.2	7.2079	82.5876
2025	10	7	20	43	31	12	0.1	1.1	34.35	93.2	7.2079	82.3475
2025	10	7	20	53	31	12	0.1	1.1	33.9	90.3	7.2079	81.3873
2025	10	7	21	3	31	12	0.1	1.1	34.45	93.2	7.2079	82.5877
2025	10	7	21	13	31	12	0.1	1.1	34.96	93.3	7.2079	83.7881
2025	10	7	21	23	31	12	0.1	1.1	33.8	90.7	7.2079	81.1473
2025	10	7	21	33	31	12	0.1	1.1	33.51	91.5	7.2018	80.3563
2025	10	7	21	43	31	12	0.1	1.1	33.64	92.9	7.2079	80.6672
2025	10	7	21	53	31	12	0.1	1.1	33.47	93.6	7.2018	80.1165
2025	10	7	22	3	31	12	0.1	1.1	34.64	92.8	7.2018	82.995
2025	10	7	22	13	31	12	0.1	1.1	34.92	91.8	7.2018	83.7146
2025	10	7	22	23	31	12	0.1	1.1	33.35	93.3	7.2018	79.8767
2025	10	7	22	33	31	12	0.1	1.1	34.06	93.5	7.2018	81.5558
2025	10	7	22	43	31	12	0.1	1.1	34.72	92	7.2018	83.235
2025	10	7	22	53	31	12	0.1	1.1	34.44	92.7	7.2018	82.5154
2025	10	7	23	3	31	12	0.1	1.1	33.43	92.4	7.2018	80.1167
2025	10	7	23	13	31	12	0.1	1.1	33.65	93.2	7.2018	80.5965
2025	10	7	23	23	31	12	0.1	1.1	34.38	94	7.2018	82.2756
2025	10	7	23	33	31	12	0.1	1.1	34.71	91.3	7.2018	83.2351
2025	10	7	23	43	31	12	0.1	1.1	34.12	92	7.2018	81.7959
2025	10	7	23	53	31	12	0.1	1.1	34.42	92.2	7.2018	82.5156

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	8	0	3	31	12	0.1	1.1	33.21	91.4	7.2018	79.6371
2025	10	8	0	13	31	12	0.1	1.1	34.84	92.8	7.2018	83.4751
2025	10	8	0	23	31	12	0.1	1.1	33.71	91.7	7.2018	80.8365
2025	10	8	0	33	31	12	0.1	1.1	34.15	93.2	7.2018	81.7961
2025	10	8	0	43	31	12	0.1	1.1	33.06	93.5	7.2018	79.1575
2025	10	8	0	53	31	12	0.1	1.1	34.32	92	7.2018	82.2758
2025	10	8	1	3	31	12	0.1	1.1	34.45	93.2	7.2018	82.5157
2025	10	8	1	13	31	12	0.1	1.1	34.72	92	7.2018	83.2354
2025	10	8	1	23	31	12	0.1	1.1	34.22	92	7.2018	82.0361
2025	10	8	1	33	31	12	0.1	1.1	33.63	92.2	7.2018	80.5969
2025	10	8	1	43	31	12	0.1	1.1	34.55	93	7.2018	82.7557
2025	10	8	1	53	31	12	0.1	1.1	34.52	92.2	7.2018	82.7558
2025	10	8	2	3	31	12	0.1	1.1	34.16	93.4	7.2018	81.7963
2025	10	8	2	13	31	12	0.1	1.1	34.54	92.8	7.2018	82.7558
2025	10	8	2	23	31	12	0.1	1.1	34.21	91	7.2018	82.0362
2025	10	8	2	33	31	12	0.1	1.1	33.45	93.3	7.2018	80.1173
2025	10	8	2	43	31	12	0.1	1.1	34.14	92.7	7.2018	81.7964
2025	10	8	2	53	31	12	0.1	1.1	33.44	92.7	7.2018	80.1173
2025	10	8	3	3	31	11.8	0.1	1.1	33.94	92.7	7.2018	81.3167
2025	10	8	3	13	31	11.8	0.1	1.1	33.99	94.2	7.2018	81.3167
2025	10	8	3	23	31	11.8	0.1	1.1	33.85	93	7.2018	81.0769
2025	10	8	3	33	31	11.8	0.1	1.1	33.41	91.5	7.2018	80.1174
2025	10	8	3	43	31	11.8	0.1	1.1	34.22	91.8	7.2018	82.0364
2025	10	8	3	53	31	11.8	0.1	1.1	34.7	90.5	7.1957	83.1625
2025	10	8	4	3	31	11.8	0.1	1.1	34.04	92.9	7.2018	81.5567
2025	10	8	4	13	31	11.8	0.1	1.1	34.6	90.7	7.2018	82.996
2025	10	8	4	23	31	11.8	0.1	1.1	33.6	90.3	7.2018	80.5973
2025	10	8	4	33	31	11.8	0.1	1.1	34.78	93.8	7.2018	83.2359
2025	10	8	4	43	31	11.8	0.1	1.1	32.77	93.7	7.2018	78.4385
2025	10	8	4	53	31	11.8	0.1	1.1	34.41	91.3	7.2018	82.5164
2025	10	8	5	3	31	11.8	0.1	1.1	33.92	92	7.2018	81.317
2025	10	8	5	13	31	11.8	0.1	1.1	34.8	90.7	7.2018	83.4759
2025	10	8	5	23	31	11.8	0.1	1.1	33.07	93.6	7.2018	79.1582
2025	10	8	5	33	31	11.8	0.1	1.1	34.31	91.5	7.2018	82.2766
2025	10	8	5	43	31	11.8	0.1	1.1	33.44	92.9	7.2018	80.1177
2025	10	8	5	53	31	11.8	0.1	1.1	34.01	91.3	7.2018	81.557
2025	10	8	6	3	31	11.8	0.1	1.1	34.66	93.3	7.2018	82.9963
2025	10	8	6	13	31	11.8	0.1	1.1	34.7	94.3	7.2018	82.9963
2025	10	8	6	23	31	11.8	0.1	1.1	33.12	92.1	7.2018	79.3982
2025	10	8	6	33	31	11.8	0.1	1.1	33.81	91.7	7.2018	81.0774
2025	10	8	6	43	31	11.8	0.1	1.1	34.14	92.7	7.2018	81.797
2025	10	8	6	53	31	11.8	0.1	1.1	34.04	92.7	7.2018	81.5572
2025	10	8	7	3	31	11.8	0.1	1.1	34.02	92	7.2018	81.5572
2025	10	8	7	13	31	11.8	0.1	1.1	33.7	90.5	7.2018	80.8376
2025	10	8	7	23	31	11.8	0.1	1.1	33.52	91.9	7.2018	80.3579
2025	10	8	7	33	31	11.8	0.1	1.1	33.73	92.2	7.2018	80.8377
2025	10	8	7	43	31	12	0.1	1.1	33.42	92.1	7.2018	80.1181
2025	10	8	7	53	31	12.4	0.1	1.1	32.63	92.3	7.2018	78.1992

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	8	8	3	31	12.6	0.1	1.1	34.55	93	7.2018	82.7568
2025	10	8	8	13	31	12.8	0.1	1.1	33.61	91.7	7.2018	80.598
2025	10	8	8	23	31	12.8	0.1	1.1	34.44	92.7	7.2018	82.517
2025	10	8	8	33	31	12.8	0.1	1.1	33.35	93.1	7.2079	79.9487
2025	10	8	8	43	31	13	0.1	1.1	34.52	92	7.2018	82.7569
2025	10	8	8	53	31	13	0.1	1.1	33.5	90.2	7.2018	80.3581
2025	10	8	9	3	31	13	0.1	1.1	33.27	93.6	7.2018	79.6385
2025	10	8	9	13	31	13	0.1	1.1	33.41	91.2	7.2018	80.1182
2025	10	8	9	23	31	13	0.1	1.1	33.72	91.9	7.2079	80.909
2025	10	8	9	33	31	13.2	0.1	1.1	33.96	93.4	7.2018	81.3176
2025	10	8	9	43	31	13.2	0.1	1.1	33.66	93.4	7.2079	80.6689
2025	10	8	9	53	31	14.2	0.1	1.1	34.42	92.2	7.2079	82.5895
2025	10	8	10	3	31	14.2	0.1	1.1	33.98	93.9	7.2079	81.3891
2025	10	8	10	13	31	14	0.1	1.1	34.52	91.8	7.2079	82.8295
2025	10	8	10	23	31	14.2	0.1	1.1	33.44	92.9	7.2079	80.1886
2025	10	8	10	33	31	14.2	0.1	1.1	34.22	92	7.2079	82.1092
2025	10	8	10	43	31	14.2	0.1	1.1	32.95	93.1	7.2079	78.988
2025	10	8	10	53	31	14.2	0.1	1.1	33.95	93	7.2079	81.3888
2025	10	8	11	3	31	14.2	0.1	1.1	34.57	93.6	7.2079	82.8293
2025	10	8	11	13	31	14.2	0.1	1.1	35.62	91.9	7.2079	85.4702
2025	10	8	11	23	31	14.2	0.1	1.1	33.98	93.9	7.2079	81.3887
2025	10	8	11	33	31	14.2	0.1	1.1	34.31	94.7	7.2079	82.1089
2025	10	8	11	43	31	14.2	0.1	1.1	34.36	93.5	7.2079	82.3489
2025	10	8	11	53	31	14.2	0.1	1.1	34.08	93.9	7.2079	81.6286
2025	10	8	12	3	31	14.2	0.1	1.1	33.94	92.7	7.2079	81.3885
2025	10	8	12	13	31	14.2	0.1	1.1	34.06	93.5	7.2079	81.6285
2025	10	8	12	23	31	14.2	0.1	1.1	33.67	93.7	7.2079	80.6681
2025	10	8	12	33	31	14.2	0.1	1.1	33.81	91.4	7.2079	81.1482
2025	10	8	12	43	31	14.2	0.1	1.1	34.03	92.5	7.2079	81.6283
2025	10	8	12	53	31	14.2	0.1	1.1	33.73	92.4	7.2079	80.908
2025	10	8	13	3	31	14.2	0.1	1.1	33.63	92.4	7.214	80.7388
2025	10	8	13	13	31	14.2	0.1	1.1	33.47	93.6	7.214	80.2582
2025	10	8	13	23	31	14.2	0.1	1.1	34.05	93	7.2201	81.7717
2025	10	8	13	33	31	14.2	0.1	1.1	33.71	91.2	7.214	80.9789
2025	10	8	13	43	31	14.2	0.1	1.1	34.24	92.8	7.214	82.1804
2025	10	8	13	53	31	14.2	0.1	1.1	33.07	93.6	7.214	79.2968
2025	10	8	14	3	31	14.2	0.1	1.1	33.45	93.3	7.2079	80.1874
2025	10	8	14	13	31	14.2	0.1	1.1	34.01	91.7	7.2079	81.6278
2025	10	8	14	23	31	14.2	0.1	1.1	33.17	93.6	7.2079	79.467
2025	10	8	14	33	31	14.2	0.1	1.1	33.81	91.5	7.2079	81.1476
2025	10	8	14	43	31	14.2	0.1	1.1	33.79	94.2	7.214	80.9786
2025	10	8	14	53	31	14.2	0.1	1.1	34.35	93	7.214	82.4203
2025	10	8	15	3	31	14.2	0.1	1.1	34.38	93.8	7.2079	82.3479
2025	10	8	15	13	31	14.2	0.1	1.1	34.22	92	7.2079	82.1077
2025	10	8	15	23	31	14.2	0.1	1.1	33.9	90.3	7.214	81.4591
2025	10	8	15	33	31	14.2	0.1	1.1	33.78	93.9	7.2079	80.9073
2025	10	8	15	43	31	14.2	0.1	1.1	33.95	93	7.2079	81.3874
2025	10	8	15	53	31	14.2	0.1	1.1	34.16	93.5	7.2079	81.8676

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	8	16	3	31	14.2	0.1	1.1	33.64	92.9	7.2018	80.5962
2025	10	8	16	13	31	14	0.1	1.1	33.91	91.4	7.2018	81.3158
2025	10	8	16	23	31	13.4	0.1	1.1	33.94	92.9	7.2079	81.3874
2025	10	8	16	33	31	14.2	0.1	1.1	33.53	92.4	7.2018	80.3563
2025	10	8	16	43	31	14.2	0.1	1.1	34.41	91.3	7.2079	82.5878
2025	10	8	16	53	31	14.2	0.1	1.1	32.94	93	7.2018	78.9171
2025	10	8	17	3	31	14	0.1	1.1	33.14	92.9	7.2018	79.3969
2025	10	8	17	13	31	13.4	0.1	1.1	33.67	93.6	7.2018	80.5962
2025	10	8	17	23	31	12.8	0.1	1.1	33.23	92.6	7.1957	79.5666
2025	10	8	17	33	31	12.6	0.1	1.1	33.76	93.4	7.2018	80.8361
2025	10	8	17	43	31	12.4	0.1	1.1	33.94	92.7	7.2018	81.3159
2025	10	8	17	53	31	12	0.1	1.1	34.31	94.7	7.2018	82.0355
2025	10	8	18	3	31	12	0.1	1.1	33.64	92.9	7.1957	80.5254
2025	10	8	18	13	31	11.4	0.1	1.1	34.04	92.9	7.2018	81.5558
2025	10	8	18	23	31	12.2	0.1	1.1	33.84	92.7	7.2018	81.0761
2025	10	8	18	33	31	12.2	0.1	1.1	33.27	93.6	7.2018	79.6369
2025	10	8	18	43	31	12.2	0.1	1.1	34.26	93.3	7.1957	81.9635
2025	10	8	18	53	31	12	0.1	1.1	34.86	93.5	7.2018	83.4749
2025	10	8	19	3	31	12	0.1	1.1	33.73	92.2	7.1957	80.7652
2025	10	8	19	13	31	11.6	0.1	1.1	34.71	91	7.2018	83.2352
2025	10	8	19	23	31	12.2	0.1	1.1	33.95	93.2	7.1957	81.2447
2025	10	8	19	33	31	11.6	0.1	1.1	33.74	92.7	7.1957	80.7654
2025	10	8	19	43	31	11.6	0.1	1.1	34.64	92.8	7.1957	82.9223
2025	10	8	19	53	31	11.4	0.1	1.1	33.74	92.7	7.1957	80.7654
2025	10	8	20	3	31	11.4	0.1	1.1	34.93	92.3	7.2018	83.7151
2025	10	8	20	13	31	11.6	0.1	1.1	34.63	92.5	7.1896	82.8494
2025	10	8	20	23	31	12	0.1	1.1	33.71	91.7	7.1957	80.7656
2025	10	8	20	33	31	12	0.1	1.1	34.25	93.2	7.1957	81.9639
2025	10	8	20	43	31	12	0.1	1.1	33.33	92.6	7.1957	79.807
2025	10	8	20	53	31	12	0.1	1.1	33.94	92.7	7.1957	81.245
2025	10	8	21	3	31	12	0.1	1.1	33.62	91.9	7.1957	80.526
2025	10	8	21	13	31	12	0.1	1.1	33.54	92.9	7.1957	80.2864
2025	10	8	21	23	31	12	0.1	1.1	33.15	93.3	7.1957	79.3278
2025	10	8	21	33	31	12	0.1	1.1	33.24	92.8	7.2018	79.6376
2025	10	8	21	43	31	12	0.1	1.1	33.22	91.7	7.1896	79.4974
2025	10	8	21	53	31	12	0.1	1.1	33.47	93.6	7.1896	79.9763
2025	10	8	22	3	31	12	0.1	1.1	33.95	93.2	7.1957	81.2452
2025	10	8	22	13	31	12	0.1	1.1	33.13	92.6	7.1957	79.3279
2025	10	8	22	23	31	12	0.1	1.1	32.76	93.5	7.1957	78.3693
2025	10	8	22	33	31	12	0.1	1.1	33.63	95.1	7.1896	80.2159
2025	10	8	22	43	31	12	0.1	1.1	34.54	92.8	7.1957	82.6833
2025	10	8	22	53	31	12	0.1	1.1	33.98	94	7.1896	81.1738
2025	10	8	23	3	31	12	0.1	1.1	34.21	91.3	7.1957	81.9643
2025	10	8	23	13	31	12	0.1	1.1	34.46	93.5	7.1957	82.4437
2025	10	8	23	23	31	12	0.1	1.1	34.36	93.5	7.1896	82.1316
2025	10	8	23	33	31	12	0.1	1.1	34.25	93.2	7.1896	81.8922
2025	10	8	23	43	31	12	0.1	1.1	34.36	93.3	7.1957	82.2041
2025	10	8	23	53	31	12	0.1	1.1	34.75	93.1	7.1896	83.0895

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	9	0	3	31	12	0.1	1.1	34.71	91.3	7.1896	83.0895
2025	10	9	0	13	31	12	0.1	1.1	33.53	95	7.1896	79.9767
2025	10	9	0	23	31	12	0.1	1.1	33.45	93.3	7.1896	79.9767
2025	10	9	0	33	31	12	0.1	1.1	34.63	92.5	7.1896	82.8501
2025	10	9	0	43	31	12	0.1	1.1	34.56	93.3	7.1896	82.6107
2025	10	9	0	53	31	12	0.1	1.1	34.08	94	7.1835	81.3416
2025	10	9	1	3	31	12	0.1	1.1	33.95	93.2	7.1957	81.2456
2025	10	9	1	13	31	12	0.1	1.1	34.34	92.8	7.1896	82.1318
2025	10	9	1	23	31	12	0.1	1.1	33.74	92.9	7.1957	80.7663
2025	10	9	1	33	31	12	0.1	1.1	34.12	92.2	7.1896	81.6529
2025	10	9	1	43	31	12	0.1	1.1	34.01	91.3	7.1896	81.4135
2025	10	9	1	53	31	12	0.1	1.1	33.17	93.6	7.1957	79.3283
2025	10	9	2	3	31	12	0.1	1.1	34.12	92.2	7.1957	81.725
2025	10	9	2	13	31	12	0.1	1.1	34.45	93	7.1957	82.444
2025	10	9	2	23	31	12	0.1	1.1	34.24	92.7	7.1896	81.8924
2025	10	9	2	33	31	12	0.1	1.1	34.33	92.5	7.1896	82.1319
2025	10	9	2	43	31	12	0.1	1.1	34.02	91.9	7.1957	81.4854
2025	10	9	2	53	31	12	0.1	1.1	34.01	91.5	7.1896	81.4136
2025	10	9	3	3	31	12	0.1	1.1	34.52	92.2	7.1896	82.6108
2025	10	9	3	13	31	12	0.1	1.1	34.74	92.6	7.1896	83.0898
2025	10	9	3	23	31	12	0.1	1.1	33.43	92.4	7.1957	80.0474
2025	10	9	3	33	31	12	0.1	1.1	34.11	94.5	7.1957	81.4854
2025	10	9	3	43	31	12	0.1	1.1	33.84	92.9	7.1957	81.0061
2025	10	9	3	53	31	12	0.1	1.1	33.82	92.2	7.1896	80.9347
2025	10	9	4	3	31	12	0.1	1.1	35.12	91.8	7.1896	84.0476
2025	10	9	4	13	31	12	0.1	1.1	34.31	91.5	7.1896	82.132
2025	10	9	4	23	31	12	0.1	1.1	32.73	92.3	7.1896	78.3008
2025	10	9	4	33	31	12	0.1	1.1	33.59	94.1	7.1896	80.2164
2025	10	9	4	43	31	11.4	0.1	1.1	34.61	91.7	7.1896	82.8503
2025	10	9	4	53	31	11.4	0.1	1.1	33.33	92.2	7.1896	79.7375
2025	10	9	5	3	31	11.4	0.1	1.1	32.55	93.2	7.1957	77.8905
2025	10	9	5	13	31	11.4	0.1	1.1	33.75	93.2	7.1957	80.7665
2025	10	9	5	23	31	11.8	0.1	1.1	33.64	92.7	7.1957	80.5268
2025	10	9	5	33	31	11.8	0.1	1.1	34.27	93.7	7.1957	81.9648
2025	10	9	5	43	31	11.8	0.1	1.1	33.25	93.3	7.1957	79.5682
2025	10	9	5	53	31	11.4	0.1	1.1	34.42	92.2	7.1957	82.4441
2025	10	9	6	3	31	11.2	0.1	1.1	33.33	92.6	7.1957	79.8078
2025	10	9	6	13	31	11.4	0.1	1.1	33.74	92.9	7.1896	80.6953
2025	10	9	6	23	31	11.8	0.1	1.1	34.12	92	7.1957	81.7252
2025	10	9	6	33	31	11.8	0.1	1.1	33.22	94.8	7.1957	79.3285
2025	10	9	6	43	31	11.8	0.1	1.1	34.12	92.2	7.1957	81.7252
2025	10	9	6	53	31	11.8	0.1	1.1	33.63	92.6	7.1957	80.5269
2025	10	9	7	3	31	11.8	0.1	1.1	34.24	92.7	7.1896	81.8926
2025	10	9	7	13	31	11.8	0.1	1.1	34.36	93.5	7.1957	82.2045
2025	10	9	7	23	31	11.8	0.1	1.1	33.84	92.7	7.1957	81.0062
2025	10	9	7	33	31	11.8	0.1	1.1	34.15	93	7.1957	81.7252
2025	10	9	7	43	31	12	0.1	1.1	34.86	93.3	7.1957	83.4029
2025	10	9	7	53	31	12.4	0.1	1.1	34.23	92.5	7.1957	81.9649

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	9	8	3	31	12.6	0.1	1.1	33.92	92.2	7.1957	81.2459
2025	10	9	8	13	31	12.6	0.1	1.1	32.85	93.1	7.1957	78.6096
2025	10	9	8	23	31	12.6	0.1	1.1	33.65	93.1	7.1957	80.5269
2025	10	9	8	33	31	12.6	0.1	1.1	32.76	93.3	7.1957	78.3699
2025	10	9	8	43	31	12.8	0.1	1.1	34.13	92.5	7.1957	81.7252
2025	10	9	8	53	31	12.8	0.1	1.1	33.75	93.1	7.1957	80.7666
2025	10	9	9	3	31	12.8	0.1	1.1	33.84	92.9	7.1957	81.0062
2025	10	9	9	13	31	12.8	0.1	1.1	34.16	93.5	7.1957	81.7252
2025	10	9	9	23	31	14.2	0.1	1.1	33.45	93.1	7.1957	80.0476
2025	10	9	9	33	31	14.2	0.1	1.1	33.05	93.3	7.1957	79.0889
2025	10	9	9	43	31	14.2	0.1	1.1	33.74	92.7	7.1957	80.7665
2025	10	9	9	53	31	13	0.1	1.1	33.82	91.9	7.1957	81.0061
2025	10	9	10	3	31	13.2	0.1	1.1	33.17	93.6	7.1957	79.3285
2025	10	9	10	13	31	13.2	0.1	1.1	33.82	94.7	7.1957	80.7664
2025	10	9	10	23	31	14.2	0.1	1.1	33.04	92.9	7.1896	79.0191
2025	10	9	10	33	31	14.2	0.1	1.1	33.09	94.2	7.1896	79.019
2025	10	9	10	43	31	14.2	0.1	1.1	33.61	91.7	7.1896	80.4557
2025	10	9	10	53	31	14.2	0.1	1.1	34.13	92.5	7.1896	81.6529
2025	10	9	11	3	31	14.2	0.1	1.1	34.16	93.5	7.1835	81.5809
2025	10	9	11	13	31	14.2	0.1	1.1	34.34	92.8	7.1896	82.1317
2025	10	9	11	23	31	14.2	0.1	1.1	33.36	93.4	7.1896	79.7372
2025	10	9	11	33	31	14.2	0.1	1.1	33.55	93.2	7.1835	80.1453
2025	10	9	11	43	31	14.2	0.1	1.1	33.64	92.7	7.1835	80.3845
2025	10	9	11	53	31	14.2	0.1	1.1	32.78	94	7.1835	78.2313
2025	10	9	12	3	31	14.2	0.1	1.1	34.02	92.2	7.1835	81.3413
2025	10	9	12	13	31	14.2	0.1	1.1	34.94	92.6	7.1774	83.4207
2025	10	9	12	23	31	14.2	0.1	1.1	33.55	93.1	7.1774	80.0743
2025	10	9	12	33	31	14.2	0.1	1.1	32.57	93.7	7.1713	77.6153
2025	10	9	12	43	31	14.2	0.1	1.1	33.27	93.8	7.1774	79.3571
2025	10	9	12	53	31	14.2	0.1	1.1	34.05	93	7.1774	81.2692
2025	10	9	13	3	31	14.2	0.1	1.1	33.69	94.3	7.1774	80.3131
2025	10	9	13	13	31	14.2	0.1	1.1	33.61	91.5	7.1713	80.2421
2025	10	9	13	23	31	14.2	0.1	1.1	34.15	93	7.1713	81.4361
2025	10	9	13	33	31	14.2	0.1	1.1	33.74	92.7	7.1713	80.4808
2025	10	9	13	43	31	14.2	0.1	1.1	33.01	91.2	7.1713	78.809
2025	10	9	13	53	31	14.2	0.1	1.1	34.35	93	7.1713	81.9135
2025	10	9	14	3	31	14.2	0.1	1.1	33.49	94.1	7.1652	79.6936
2025	10	9	14	13	31	14.2	0.1	1.1	33.95	93.2	7.1652	80.8866
2025	10	9	14	23	31	14.2	0.1	1.1	33.82	91.9	7.1652	80.648
2025	10	9	14	33	31	14.2	0.1	1.1	33.55	93.2	7.1591	79.8613
2025	10	9	14	43	31	14.2	0.1	1.1	33.39	94.1	7.153	79.3142
2025	10	9	14	53	31	14.2	0.1	1.1	34.28	93.8	7.153	81.4578
2025	10	9	15	3	31	14.2	0.1	1.1	33.22	92.1	7.153	79.076
2025	10	9	15	13	31	14.2	0.1	1.1	33.58	93.9	7.153	79.7905
2025	10	9	15	23	31	14.2	0.1	1.1	33.92	92.2	7.153	80.7432
2025	10	9	15	33	31	14.2	0.1	1.1	33.74	92.7	7.147	80.1956
2025	10	9	15	43	31	14.2	0.1	1.1	33.27	93.6	7.1409	78.9356
2025	10	9	15	53	31	14.2	0.1	1.1	32.44	93	7.1409	77.0335

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	9	16	3	31	14.2	0.1	1.1	33.84	92.7	7.1409	80.3621
2025	10	9	16	13	31	14	0.1	1.1	32.63	92.3	7.1409	77.509
2025	10	9	16	23	31	13.6	0.1	1.1	32.37	93.9	7.1348	76.7275
2025	10	9	16	33	31	13.6	0.1	1.1	33.66	93.4	7.1348	79.8156
2025	10	9	16	43	31	13.6	0.1	1.1	32.87	93.7	7.1348	77.9153
2025	10	9	16	53	31	13.6	0.1	1.1	33.23	92.2	7.1287	78.7953
2025	10	9	17	3	31	13.6	0.1	1.1	34.05	93	7.1226	80.6222
2025	10	9	17	13	31	13.2	0.1	1.1	33.23	92.4	7.1226	78.7253
2025	10	9	17	23	31	13.2	0.1	1.1	32.54	93	7.1165	76.9968
2025	10	9	17	33	31	12.8	0.1	1.1	32.81	91.4	7.1165	77.7075
2025	10	9	17	43	31	12.2	0.1	1.1	33.83	92.4	7.1165	80.0767
2025	10	9	17	53	31	12.2	0.1	1.1	33.67	93.6	7.1104	79.5319
2025	10	9	18	3	31	12.2	0.1	1.1	33.07	93.6	7.1104	78.1117
2025	10	9	18	13	31	12.2	0.1	1.1	33.43	92.6	7.1043	78.9881
2025	10	9	18	23	31	12.2	0.1	1.1	32.67	93.7	7.0982	77.0273
2025	10	9	18	33	31	12.2	0.1	1.1	33.63	92.6	7.0982	79.3901
2025	10	9	18	43	31	12.2	0.1	1.1	32.82	94.9	7.0982	77.2636
2025	10	9	18	53	31	12.2	0.1	1.1	33.91	91.2	7.0982	80.099
2025	10	9	19	3	31	12.2	0.1	1.1	33.12	91.7	7.0921	78.1389
2025	10	9	19	13	31	12.2	0.1	1.1	33.13	92.2	7.0921	78.139
2025	10	9	19	23	31	12.2	0.1	1.1	32.36	93.4	7.086	76.1822
2025	10	9	19	33	31	12.2	0.1	1.1	33.65	93.2	7.0799	79.1775
2025	10	9	19	43	31	12	0.1	1.1	33.48	93.9	7.0799	78.7062
2025	10	9	19	53	31	12	0.1	1.1	33.63	92.2	7.0738	79.1066
2025	10	9	20	3	31	12	0.1	1.1	32.74	93	7.0738	76.9877
2025	10	9	20	13	31	12	0.1	1.1	33.04	92.8	7.0677	77.6244
2025	10	9	20	23	31	12	0.1	1.1	33.56	93.4	7.0677	78.8005
2025	10	9	20	33	31	12	0.1	1.1	33.53	92.2	7.0677	78.8005
2025	10	9	20	43	31	12	0.1	1.1	32.34	93	7.0677	75.9779
2025	10	9	20	53	31	12	0.1	1.1	32.24	93	7.0616	75.6747
2025	10	9	21	3	31	12	0.1	1.1	32.43	92.3	7.0555	76.0763
2025	10	9	21	13	31	12	0.1	1.1	32.57	93.7	7.0494	76.2426
2025	10	9	21	23	31	12	0.1	1.1	32.11	91.6	7.0494	75.3042
2025	10	9	21	33	31	12	0.1	1	31.61	91.5	7.0433	74.0646
2025	10	9	21	43	31	12	0.1	1	32.92	92.1	7.0433	77.1115
2025	10	9	21	53	31	12	0.1	1	32.02	92.1	7.0433	75.0021
2025	10	9	22	3	31	12	0.1	1	32.93	95.1	7.0372	76.8079
2025	10	9	22	13	31	12	0.1	1	32.73	92.6	7.0311	76.5048
2025	10	9	22	23	31	12	0.1	1	32.44	93	7.0311	75.8029
2025	10	9	22	33	31	12	0.1	1	32.53	92.3	7.0311	76.0369
2025	10	9	22	43	31	12	0.1	1	32.13	92.5	7.025	75.0333
2025	10	9	22	53	31	12	0.1	1	33.24	92.9	7.0189	77.5345
2025	10	9	23	3	31	12	0.1	1	32.95	93.1	7.0189	76.8339
2025	10	9	23	13	31	12	0.1	1	32.42	92.1	7.0189	75.6662
2025	10	9	23	23	31	12	0.1	1	32.03	92.5	7.0189	74.7321
2025	10	9	23	33	31	12	0.1	1	32.61	91.6	7.0067	75.9957
2025	10	9	23	43	31	12	0.1	1	32.16	93.4	7.0128	74.8979
2025	10	9	23	53	31	12	0.1	1	32	90.7	7.0067	74.597

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	10	0	3	31	12	0.1	1	32.94	93	7.0067	76.695
2025	10	10	0	13	31	12	0.1	1	32.97	93.7	7.0006	76.6256
2025	10	10	0	23	31	12	0.1	1	30.38	94.2	7.0006	70.5701
2025	10	10	0	33	31	12	0.1	1	31.42	91.8	6.9945	73.0658
2025	10	10	0	43	31	12	0.1	1	33.19	94.3	6.9945	77.0215
2025	10	10	0	53	31	12	0.1	1	31.18	94.2	6.9945	72.3677
2025	10	10	1	3	31	12	0.1	1	31.65	93.1	6.9945	73.5312
2025	10	10	1	13	31	12	0.1	1	31.64	92.9	6.9885	73.4645
2025	10	10	1	23	31	12	0.1	1	32.89	94.2	6.9885	76.2543
2025	10	10	1	33	31	12	0.1	1	32.74	95.3	6.9885	75.7893
2025	10	10	1	43	31	12	0.1	1	32.44	92.8	6.9824	75.2559
2025	10	10	1	53	31	12	0.1	1	31.95	93.1	6.9885	74.1619
2025	10	10	2	3	31	12	0.1	1	31.21	91.5	6.9824	72.4687
2025	10	10	2	13	31	12	0.1	1	32.54	93	6.9763	75.4196
2025	10	10	2	23	31	12	0.1	1	32.01	91.6	6.9763	74.2593
2025	10	10	2	33	31	12	0.1	1	32.34	93	6.9763	74.9555
2025	10	10	2	43	31	12	0.1	1	31.6	94.5	6.9763	73.099
2025	10	10	2	53	31	12	0.1	1	31.92	91.8	6.9702	73.9599
2025	10	10	3	3	31	12	0.1	1	31.75	93.1	6.9641	73.4293
2025	10	10	3	13	31	12	0.1	1	32.37	93.9	6.9641	74.8192
2025	10	10	3	23	31	12	0.1	1	31.71	91.4	6.9641	73.4293
2025	10	10	3	33	31	12	0.1	1	31.96	93.6	6.9641	73.8926
2025	10	10	3	43	31	12	0.1	1	33.21	94.7	6.958	76.6024
2025	10	10	3	53	31	12	0.1	1	31.66	93.4	6.9641	73.1977
2025	10	10	4	3	31	12	0.1	1	32.43	92.7	6.9641	75.0508
2025	10	10	4	13	31	12	0.1	1	32.37	93.7	6.958	74.751
2025	10	10	4	23	31	12	0.1	1	32.46	93.5	6.958	74.9825
2025	10	10	4	33	31	12	0.1	1	31.74	92.7	6.958	73.3625
2025	10	10	4	43	31	12	0.1	1	31.91	91.1	6.958	73.8253
2025	10	10	4	53	31	12	0.1	1	31.45	93.1	6.9519	72.6019
2025	10	10	5	3	31	12	0.1	1	31.51	91.5	6.9519	72.8331
2025	10	10	5	13	31	11.8	0.1	1	31.6	94.5	6.9458	72.7667
2025	10	10	5	23	31	11.8	0.1	1	32.14	92.9	6.9458	74.1527
2025	10	10	5	33	31	11.8	0.1	1	31.51	91.6	6.9458	72.7667
2025	10	10	5	43	31	11.8	0.1	1	32.33	92.3	6.9397	74.5466
2025	10	10	5	53	31	11.8	0.1	1	31.91	91.3	6.9458	73.6907
2025	10	10	6	3	31	11.8	0.1	1	32.06	93.6	6.9397	73.8542
2025	10	10	6	13	31	11.8	0.1	1	32.52	92.1	6.9397	75.0082
2025	10	10	6	23	31	11.8	0.1	1	32.84	92.8	6.9336	75.6313
2025	10	10	6	33	31	11.8	0.1	1	30.41	91.5	6.9336	70.0973
2025	10	10	6	43	31	11.8	0.1	1	31.55	93.3	6.9336	72.6337
2025	10	10	6	53	31	11.8	0.1	1	30.74	92.8	6.9275	70.7243
2025	10	10	7	3	31	11.8	0.1	1	31.42	91.8	6.9275	72.3369
2025	10	10	7	13	31	11.8	0.1	1	32.86	93.5	6.9275	75.5621
2025	10	10	7	23	31	11.8	0.1	1	32.61	91.1	6.9275	75.1014
2025	10	10	7	33	31	11.8	0.1	1	31.85	93.1	6.9275	73.2584
2025	10	10	7	43	31	12	0.1	1	31.95	93.1	6.9275	73.4888
2025	10	10	7	53	31	12.2	0.1	1	32.37	93.9	6.9275	74.4103

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	10	8	3	31	12.4	0.1	1	31.91	94.9	6.9275	73.2584
2025	10	10	8	13	31	12.6	0.1	1	30.74	92.8	6.9214	70.6595
2025	10	10	8	23	31	12.6	0.1	1	31.98	93.9	6.9214	73.4215
2025	10	10	8	33	31	12.6	0.1	1	31.92	91.8	6.9275	73.4888
2025	10	10	8	43	31	12.8	0.1	1	32.38	94.1	6.9275	74.4103
2025	10	10	8	53	31	13	0.1	1	32	94.5	6.9275	73.4888
2025	10	10	9	3	31	14.2	0.1	1	30.73	92.6	6.9214	70.6595
2025	10	10	9	13	31	14.2	0.1	1	31.66	93.4	6.9214	72.7309
2025	10	10	9	23	31	14.2	0.1	1	31.91	91.4	6.9214	73.4214
2025	10	10	9	33	31	14.2	0.1	1	31.97	93.8	6.9214	73.4214
2025	10	10	9	43	31	14.2	0.1	1	31.55	93.1	6.9214	72.5007
2025	10	10	9	53	31	14.2	0.1	1	32.09	94.3	6.9214	73.6515
2025	10	10	10	3	31	14.2	0.1	1	32.25	93.2	6.9153	74.0438
2025	10	10	10	13	31	14	0.1	1	31.88	94	6.9153	73.124
2025	10	10	10	23	31	14.2	0.1	1	30.76	93.5	6.9153	70.5945
2025	10	10	10	33	31	14.2	0.1	1	31.33	92.6	6.9153	71.9742
2025	10	10	10	43	31	14.2	0.1	1	31.06	93.5	6.9092	71.2189
2025	10	10	10	53	31	14.2	0.1	1	32.2	94.5	6.9153	73.8137
2025	10	10	11	3	31	14.2	0.1	1	31.08	94.1	6.9153	71.2842
2025	10	10	11	13	31	14.2	0.1	1	30.67	93.7	6.9153	70.3643
2025	10	10	11	23	31	14.2	0.1	1	30.96	93.7	6.9092	70.9889
2025	10	10	11	33	31	14.2	0.1	1	31.5	94.6	6.9092	72.1376
2025	10	10	11	43	31	14.2	0.1	1	30.47	94	6.9092	69.8401
2025	10	10	11	53	31	14.2	0.1	1	30.95	95.6	6.9092	70.759
2025	10	10	12	3	31	14.2	0.1	1	30.83	92.4	6.9031	70.694
2025	10	10	12	13	31	14.2	0.1	1	30.53	92.6	6.9092	70.0697
2025	10	10	12	23	31	14	0.1	1	30.62	91.9	6.9031	70.2348
2025	10	10	12	33	31	14.2	0.1	1	31.51	91.6	6.9031	72.3005
2025	10	10	12	43	31	14.2	0.1	1	32.34	92.8	6.9031	74.1366
2025	10	10	12	53	31	14.2	0.1	1	31.05	93.3	6.897	71.0873
2025	10	10	13	3	31	14.2	0.1	1	30.11	91.5	6.897	69.0234
2025	10	10	13	13	31	14.2	0.1	1	32.09	94.3	6.897	73.3803
2025	10	10	13	23	31	14.2	0.1	1	31.41	91.5	6.9031	72.0706
2025	10	10	13	33	31	14.2	0.1	1	31.86	93.6	6.8909	72.8545
2025	10	10	13	43	31	14.2	0.1	1	30.51	91.7	6.897	69.9404
2025	10	10	13	53	31	14.2	0.1	1	31.24	92.9	6.8909	71.4797
2025	10	10	14	3	31	14.2	0.1	1	30.83	92.6	6.8909	70.5633
2025	10	10	14	13	31	14	0.1	1	30.36	93.6	6.897	69.4817
2025	10	10	14	23	31	14.2	0.1	1	30.98	94.1	6.8848	70.7271
2025	10	10	14	33	31	14.2	0.1	1	31.22	91.8	6.8848	71.4137
2025	10	10	14	43	31	14.2	0.1	1	31.33	95.1	6.8848	71.4137
2025	10	10	14	53	31	14.2	0.1	1	31.51	91.6	6.8909	72.1668
2025	10	10	15	3	31	14.2	0.1	1	31.67	93.8	6.8848	72.3291
2025	10	10	15	13	31	14.2	0.1	1	31.84	92.9	6.8848	72.7869
2025	10	10	15	23	31	14.2	0.1	1	31.33	92.6	6.8787	71.5763
2025	10	10	15	33	31	14.2	0.1	1	31.84	92.9	6.8848	72.7868
2025	10	10	15	43	31	14.2	0.1	1	30.81	91.1	6.8848	70.4979
2025	10	10	15	53	31	14.2	0.1	1	31.05	93.1	6.8909	71.0211

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	10	16	3	31	14.2	0.1	1	30.3	90.8	6.8848	69.3534
2025	10	10	16	13	31	14	0.1	1	31.89	94.3	6.8787	72.7196
2025	10	10	16	23	31	13.4	0.1	1	30.51	91.7	6.8787	69.7468
2025	10	10	16	33	31	13.6	0.1	1	31.33	92.4	6.8787	71.5762
2025	10	10	16	43	31	13.6	0.1	1	31.05	93.1	6.8726	70.8247
2025	10	10	16	53	31	13.6	0.1	1	31.92	92	6.8787	72.9482
2025	10	10	17	3	31	13.6	0.1	1	30.51	91.7	6.8726	69.6824
2025	10	10	17	13	31	13.6	0.1	1	31.03	92.6	6.8787	70.8901
2025	10	10	17	23	31	13.4	0.1	1	31.18	94	6.8787	71.1188
2025	10	10	17	33	31	12.8	0.1	1	32.21	91.6	6.8787	73.6343
2025	10	10	17	43	31	12.2	0.1	1	30.78	94.1	6.8726	70.1394
2025	10	10	17	53	31	12.2	0.1	1	32.35	93.2	6.8726	73.7948
2025	10	10	18	3	31	12.2	0.1	1	31.73	92.3	6.8787	72.4909
2025	10	10	18	13	31	12.2	0.1	1	31.46	93.5	6.8726	71.7387
2025	10	10	18	23	31	12.2	0.1	1	31.04	92.8	6.8726	70.8248
2025	10	10	18	33	31	12.2	0.1	1	31.03	92.6	6.8787	70.8903
2025	10	10	18	43	31	12.2	0.1	1	31.72	92.2	6.8726	72.4242
2025	10	10	18	53	31	12.2	0.1	1	31.81	91.6	6.8726	72.6526
2025	10	10	19	3	31	12.2	0.1	1	30.94	92.8	6.8726	70.5965
2025	10	10	19	13	31	12.2	0.1	1	31.73	92.3	6.8787	72.4911
2025	10	10	19	23	31	12.2	0.1	1	31.35	93.3	6.8787	71.5764
2025	10	10	19	33	31	12.2	0.1	1	31.94	92.9	6.8787	72.9486
2025	10	10	19	43	31	12.2	0.1	1	31.93	92.3	6.8726	72.8813
2025	10	10	19	53	31	12	0.1	1	31.16	93.5	6.8726	71.0536
2025	10	10	20	3	31	12	0.1	1	31.55	93.3	6.8787	72.0339
2025	10	10	20	13	31	12	0.1	1	30.22	92.3	6.8787	69.0611
2025	10	10	20	23	31	12	0.1	1	31.8	94.5	6.8726	72.4245
2025	10	10	20	33	31	12	0.1	1	31.23	92.4	6.8787	71.348
2025	10	10	20	43	31	12	0.1	1	31.58	94	6.8726	71.9676
2025	10	10	20	53	31	12	0.1	1	30.55	93.4	6.8726	69.683
2025	10	10	21	3	31	12	0.1	1	30.85	93.3	6.8665	70.3034
2025	10	10	21	13	31	12	0.1	1	31.12	92.2	6.8726	71.0538
2025	10	10	21	23	31	12	0.1	1	31.86	93.6	6.8726	72.6532
2025	10	10	21	33	31	12	0.1	1	31.35	93.1	6.8665	71.4448
2025	10	10	21	43	31	12	0.1	1	31.21	91.7	6.8726	71.2824
2025	10	10	21	53	31	12	0.1	1	32.65	93.2	6.8726	74.481
2025	10	10	22	3	31	12	0.1	1	31.33	92.4	6.8787	71.577
2025	10	10	22	13	31	12	0.1	1	31.15	93.1	6.8726	71.054
2025	10	10	22	23	31	12	0.1	1	31.16	93.7	6.8726	71.054
2025	10	10	22	33	31	12	0.1	1	31.54	92.9	6.8726	71.9679
2025	10	10	22	43	31	12	0.1	1	31.35	93.3	6.8665	71.445
2025	10	10	22	53	31	12	0.1	1	31.82	91.8	6.8726	72.6534
2025	10	10	23	3	31	12	0.1	1	31.01	91.7	6.8726	70.8257
2025	10	10	23	13	31	12	0.1	1	31.43	92.4	6.8726	71.7395
2025	10	10	23	23	31	12	0.1	1	31.81	91.4	6.8726	72.6535
2025	10	10	23	33	31	12	0.1	1	31.15	93.3	6.8726	71.0542
2025	10	10	23	43	31	12	0.1	1	31.43	92.4	6.8726	71.7396
2025	10	10	23	53	31	12	0.1	1	32.36	93.5	6.8726	73.7959

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	11	0	3	31	12	0.1	1	31.23	92.6	6.8726	71.2827
2025	10	11	0	13	31	12	0.1	1	31.08	94.1	6.8726	70.8258
2025	10	11	0	23	31	12	0.1	1	31.33	92.4	6.8726	71.5112
2025	10	11	0	33	31	12	0.1	1	31.48	94.2	6.8726	71.7397
2025	10	11	0	43	31	12	0.1	1	31.18	94.2	6.8726	71.0543
2025	10	11	0	53	31	12	0.1	1	31.05	93.1	6.8787	70.8913
2025	10	11	1	3	31	12	0.1	1	30.83	92.4	6.8787	70.434
2025	10	11	1	13	31	12	0.1	1	31.23	92.6	6.8787	71.3487
2025	10	11	1	23	31	12	0.1	1	30.35	93.2	6.8787	69.2906
2025	10	11	1	33	31	12	0.1	1	31.83	92.3	6.8787	72.7208
2025	10	11	1	43	31	12	0.1	1	31.07	93.9	6.8787	70.8914
2025	10	11	1	53	31	12	0.1	1	31.7	90.5	6.8787	72.4922
2025	10	11	2	3	31	12	0.1	1	31.11	91.7	6.8787	71.1201
2025	10	11	2	13	31	12	0.1	1	30.93	92.4	6.8787	70.6627
2025	10	11	2	23	31	12	0.1	1	30.92	92.2	6.8848	70.728
2025	10	11	2	33	31	12	0.1	1	30.62	91.9	6.8848	70.0413
2025	10	11	2	43	31	12	0.1	1	32.21	91.1	6.8909	73.7715
2025	10	11	2	53	31	12	0.1	1	31.7	90.7	6.8848	72.5591
2025	10	11	3	3	31	12	0.1	1	32.29	94.3	6.8848	73.7036
2025	10	11	3	13	31	12	0.1	1	31.35	93.1	6.8909	71.7096
2025	10	11	3	23	31	12	0.1	1	30.65	93.2	6.8909	70.1059
2025	10	11	3	33	31	12	0.1	1	31.65	93.3	6.8909	72.397
2025	10	11	3	43	31	12	0.1	1	31.53	92.4	6.8909	72.1679
2025	10	11	3	53	31	12	0.1	1	30.95	93.1	6.897	70.8585
2025	10	11	4	3	31	12	0.1	1	31.56	93.5	6.8909	72.168
2025	10	11	4	13	31	11.8	0.1	1	29.71	94.8	6.897	67.8774
2025	10	11	4	23	31	11.8	0.1	1	31.45	93.3	6.897	72.0051
2025	10	11	4	33	31	11.8	0.1	1	30.93	92.4	6.897	70.8586
2025	10	11	4	43	31	11.8	0.1	1	31.8	94.5	6.897	72.6932
2025	10	11	4	53	31	11.8	0.1	1	31.68	94	6.897	72.4639
2025	10	11	5	3	31	11.8	0.1	1	30.94	92.8	6.897	70.8587
2025	10	11	5	13	31	11.8	0.1	1	31.72	92	6.897	72.6932
2025	10	11	5	23	31	11.8	0.1	1	32.01	91.1	6.897	73.3812
2025	10	11	5	33	31	11.8	0.1	1	31	90	6.897	71.0881
2025	10	11	5	43	31	11.8	0.1	1	31.7	94.5	6.897	72.464
2025	10	11	5	53	31	11.8	0.1	1	32.67	93.9	6.897	74.7572
2025	10	11	6	3	31	11.8	0.1	1	31.63	92.5	6.897	72.4641
2025	10	11	6	13	31	11.8	0.1	1	31.51	94.7	6.897	72.0055
2025	10	11	6	23	31	11.8	0.1	1	32.43	92.7	6.897	74.2987
2025	10	11	6	33	31	11.8	0.1	1	32.43	92.3	6.897	74.2988
2025	10	11	6	43	31	11.8	0.1	1	31.92	91.8	6.897	73.1522
2025	10	11	6	53	31	11.8	0.1	1	30.63	92.6	6.897	70.1711
2025	10	11	7	3	31	11.8	0.1	1	32.14	93	6.897	73.6109
2025	10	11	7	13	31	11.8	0.1	1	31.06	93.5	6.9031	71.1539
2025	10	11	7	23	31	11.8	0.1	1	32.36	93.5	6.897	74.0696
2025	10	11	7	33	31	11.8	0.1	1	30.95	93.3	6.897	70.8592
2025	10	11	7	43	31	12	0.1	1	31.26	93.7	6.9031	71.613
2025	10	11	7	53	31	12.4	0.1	1	30.34	93	6.897	69.4833

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	11	8	3	31	12.6	0.1	1	32.1	90.7	6.897	73.6111
2025	10	11	8	13	31	12.8	0.1	1	30.7	94.7	6.897	70.1713
2025	10	11	8	23	31	12.8	0.1	1	31.24	92.8	6.9031	71.6131
2025	10	11	8	33	31	12.8	0.1	1	30.52	92.1	6.9031	70.0064
2025	10	11	8	43	31	12.8	0.1	1	31.81	91.4	6.9031	72.9903
2025	10	11	8	53	31	12.8	0.1	1	31.05	93.1	6.9031	71.1541
2025	10	11	9	3	31	13	0.1	1	32.44	93	6.9031	74.3675
2025	10	11	9	13	31	13.2	0.1	1	31.15	93.1	6.9031	71.3836
2025	10	11	9	23	31	13.2	0.1	1	31.05	93.1	6.9031	71.1541
2025	10	11	9	33	31	13.2	0.1	1	31.41	91.6	6.9031	72.0722
2025	10	11	9	43	31	13.4	0.1	1	29.31	91.8	6.9031	67.252
2025	10	11	9	53	31	13.6	0.1	1	32.08	93.9	6.9031	73.4493
2025	10	11	10	3	31	14.2	0.1	1	31.86	93.4	6.9031	72.9902
2025	10	11	10	13	31	14.2	0.1	1	31.53	92.4	6.9031	72.3016
2025	10	11	10	23	31	14.2	0.1	1	30.11	91.7	6.9031	69.0882
2025	10	11	10	33	31	14.2	0.1	1	30.95	93.3	6.9031	70.9243
2025	10	11	10	43	31	14.2	0.1	1	32.34	93	6.9031	74.1377
2025	10	11	10	53	31	14.2	0.1	1	31.07	93.9	6.9031	71.1538
2025	10	11	11	3	31	14.2	0.1	1	30.71	91.7	6.9031	70.4652
2025	10	11	11	13	31	14.2	0.1	1	30.55	93.2	6.9031	70.0061
2025	10	11	11	23	31	14.2	0.1	1	30.83	92.6	6.9031	70.6946
2025	10	11	11	33	31	14.2	0.1	1	31.42	92.2	6.9031	72.0717
2025	10	11	11	43	31	14.2	0.1	1	31.01	91.7	6.9031	71.1536
2025	10	11	11	53	31	14.2	0.1	1	31.4	90.7	6.9031	72.0716
2025	10	11	12	3	31	14.2	0.1	1	31.11	91.7	6.9031	71.383
2025	10	11	12	13	31	14.2	0.1	1	31.01	91.1	6.9031	71.1534
2025	10	11	12	23	31	14.2	0.1	1	30.43	92.4	6.9031	69.7762
2025	10	11	12	33	31	14.2	0.1	1	30.81	91.3	6.9031	70.6943
2025	10	11	12	43	31	14.2	0.1	1	32.11	91.6	6.897	73.6103
2025	10	11	12	53	31	14.2	0.1	1	31.03	92.4	6.897	71.0878
2025	10	11	13	3	31	14.2	0.1	1	31.31	91.6	6.8909	71.7097
2025	10	11	13	13	31	14	0.1	1	30.42	92.3	6.8909	69.6477
2025	10	11	13	23	31	14.2	0.1	1	32.07	93.8	6.8848	73.2458
2025	10	11	13	33	31	14.2	0.1	1	31.7	90.9	6.8909	72.626
2025	10	11	13	43	31	14.2	0.1	1	31.35	93.1	6.8848	71.6435
2025	10	11	13	53	31	14.2	0.1	1	31.26	93.5	6.8848	71.4146
2025	10	11	14	3	31	14.2	0.1	1	31.43	92.4	6.8909	71.9386
2025	10	11	14	13	31	14	0.1	1	31.12	92.2	6.8909	71.2513
2025	10	11	14	23	31	13.8	0.1	1	31.21	91.7	6.8909	71.4803
2025	10	11	14	33	31	14.2	0.1	1	30.73	92.4	6.8909	70.3348
2025	10	11	14	43	31	13.4	0.1	1	31.44	92.7	6.8848	71.8722
2025	10	11	14	53	31	13.4	0.1	1	30.91	91.1	6.8787	70.6625
2025	10	11	15	3	31	13.6	0.1	1	29.96	93.6	6.8787	68.3757
2025	10	11	15	13	31	13.4	0.1	1	31.53	92.4	6.8726	71.9681
2025	10	11	15	23	31	13.6	0.1	1	31.91	91.3	6.8726	72.882
2025	10	11	15	33	31	14.2	0.1	1	31.66	93.6	6.8726	72.1965
2025	10	11	15	43	31	14.2	0.1	1	31.15	93.1	6.8726	71.0542
2025	10	11	15	53	31	14.2	0.1	1	30.55	93.4	6.8726	69.6834

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	11	16	3	31	14.2	0.1	1	31.43	92.4	6.8787	71.8058
2025	10	11	16	13	31	14	0.1	1	31.13	92.4	6.8726	71.0542
2025	10	11	16	23	31	13.2	0.1	1	31.27	93.9	6.8726	71.2826
2025	10	11	16	33	31	13.2	0.1	1	31.93	92.3	6.8726	72.8819
2025	10	11	16	43	31	13.4	0.1	1	31.66	93.6	6.8726	72.1965
2025	10	11	16	53	31	13.4	0.1	1	31.46	93.5	6.8726	71.7396
2025	10	11	17	3	31	13.4	0.1	1	31.71	94.7	6.8665	72.1299
2025	10	11	17	13	31	13.4	0.1	1	32.03	92.5	6.8665	73.0429
2025	10	11	17	23	31	13.4	0.1	1	31.09	94.2	6.8665	70.7604
2025	10	11	17	33	31	12.8	0.1	1	31.51	91.5	6.8665	71.9017
2025	10	11	17	43	31	12.2	0.1	1	31.56	93.5	6.8665	71.9017
2025	10	11	17	53	31	12.2	0.1	1	31.76	93.4	6.8665	72.3583
2025	10	11	18	3	31	12.2	0.1	1	31.64	92.7	6.8665	72.13
2025	10	11	18	13	31	12.2	0.1	1	31.23	92.6	6.8665	71.217
2025	10	11	18	23	31	12.2	0.1	1	31.28	94	6.8665	71.2171
2025	10	11	18	33	31	12.2	0.1	1	30.71	91.5	6.8665	70.0758
2025	10	11	18	43	31	12.2	0.1	1	30.91	91.1	6.8665	70.5323
2025	10	11	18	53	31	12.2	0.1	1	30.32	91.9	6.8665	69.1628
2025	10	11	19	3	31	12.2	0.1	1	31.37	93.8	6.8665	71.4455
2025	10	11	19	13	31	12.2	0.1	1	31.54	92.9	6.8665	71.902
2025	10	11	19	23	31	12.2	0.1	1	32.44	93	6.8665	73.9564
2025	10	11	19	33	31	12.2	0.1	1	30.64	92.8	6.8726	69.9123
2025	10	11	19	43	31	12.2	0.1	1	30.92	92.2	6.8665	70.5326
2025	10	11	19	53	31	12.2	0.1	1	31.32	92	6.8665	71.4457
2025	10	11	20	3	31	12	0.1	1	32.3	94.6	6.8665	73.5001
2025	10	11	20	13	31	12	0.1	1	31.13	92.4	6.8726	71.0549
2025	10	11	20	23	31	12	0.1	1	31.25	93.1	6.8726	71.2834
2025	10	11	20	33	31	12	0.1	1	32.11	91.6	6.8726	73.3397
2025	10	11	20	43	31	12	0.1	1	31.01	91.7	6.8665	70.7611
2025	10	11	20	53	31	12	0.1	1	29.93	92.5	6.8726	68.3134
2025	10	11	21	3	31	12	0.1	1	31.1	90	6.8787	71.1207
2025	10	11	21	13	31	12	0.1	1	31.17	93.9	6.8726	71.0551
2025	10	11	21	23	31	12	0.1	1	30.61	91.3	6.8726	69.9128
2025	10	11	21	33	31	12	0.1	1	31.42	94.9	6.8726	71.5122
2025	10	11	21	43	31	12	0.1	1	30.82	92	6.8787	70.4348
2025	10	11	21	53	31	12	0.1	1	31.14	95.3	6.8726	70.8269
2025	10	11	22	3	31	12	0.1	1	30.61	91.7	6.8726	69.913
2025	10	11	22	13	31	12	0.1	1	31.75	93.1	6.8726	72.4262
2025	10	11	22	23	31	12	0.1	1	30.21	91.1	6.8726	68.9992
2025	10	11	22	33	31	12	0.1	1	31.61	91.6	6.8726	72.1978
2025	10	11	22	43	31	12	0.1	1	31.5	90.7	6.8726	71.9694
2025	10	11	22	53	31	12	0.1	1	30.83	92.4	6.8726	70.3701
2025	10	11	23	3	31	12	0.1	1	31.24	92.8	6.8787	71.3499
2025	10	11	23	13	31	12	0.1	1	31.26	93.7	6.8726	71.2841
2025	10	11	23	23	31	12	0.1	1	30.72	92.2	6.8787	70.2066
2025	10	11	23	33	31	12	0.1	1	31.55	93.3	6.8787	72.0361
2025	10	11	23	43	31	12	0.1	1	31.5	90.4	6.8726	71.9697
2025	10	11	23	53	31	12	0.1	1	32.24	93	6.8726	73.569

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	12	0	3	31	12	0.1	1	30.77	93.7	6.8726	70.1419
2025	10	12	0	13	31	12	0.1	1	30.5	90	6.8787	69.7494
2025	10	12	0	23	31	12	0.1	1	30.37	94	6.8787	69.292
2025	10	12	0	33	31	12	0.1	1	30.24	92.8	6.8787	69.0634
2025	10	12	0	43	31	12	0.1	1	31.33	92.4	6.8787	71.579
2025	10	12	0	53	31	12	0.1	1	31.56	93.6	6.8787	72.0364
2025	10	12	1	3	31	12	0.1	1	31.24	92.9	6.8787	71.3503
2025	10	12	1	13	31	12	0.1	1	30.5	90.9	6.8787	69.7495
2025	10	12	1	23	31	12	0.1	1	30.57	93.9	6.8787	69.7496
2025	10	12	1	33	31	12	0.1	1	31.23	92.4	6.8848	71.4163
2025	10	12	1	43	31	12	0.1	1	30.62	92.1	6.8787	69.9783
2025	10	12	1	53	31	12	0.1	1	31.53	92.4	6.8787	72.0365
2025	10	12	2	3	31	12	0.1	1	31.15	93.1	6.8787	71.1218
2025	10	12	2	13	31	12	0.1	1	30.54	92.8	6.8787	69.7497
2025	10	12	2	23	31	12	0.1	1	30.65	93.2	6.8787	69.9784
2025	10	12	2	33	31	12	0.1	1	31.09	94.2	6.8787	70.8932
2025	10	12	2	43	31	12	0.1	1	30.33	92.5	6.8787	69.2924
2025	10	12	2	53	31	12	0.1	1	30.64	93	6.8787	69.9785
2025	10	12	3	3	31	12	0.1	1	31.91	91.6	6.8787	72.9515
2025	10	12	3	13	31	12	0.1	1	31.9	94.5	6.8787	72.7228
2025	10	12	3	23	31	12	0.1	1	31.62	92.2	6.8787	72.2655
2025	10	12	3	33	31	12	0.1	1	31.38	94.2	6.8787	71.5794
2025	10	12	3	43	31	12	0.1	1	31.05	93.1	6.8787	70.8934
2025	10	12	3	53	31	12	0.1	1	30.77	93.9	6.8787	70.2073
2025	10	12	4	3	31	11.8	0.1	1	30.95	93.1	6.8787	70.6647
2025	10	12	4	13	31	11.8	0.1	1	30.74	93	6.8787	70.2074
2025	10	12	4	23	31	11.8	0.1	1	30.96	93.5	6.8787	70.6648
2025	10	12	4	33	31	11.8	0.1	1	31.71	91.3	6.8848	72.5612
2025	10	12	4	43	31	11.8	0.1	1	31.92	92.2	6.8787	72.9517
2025	10	12	4	53	31	11.8	0.1	1	30.94	92.8	6.8787	70.6649
2025	10	12	5	3	31	11.8	0.1	1	30.94	93	6.8787	70.6649
2025	10	12	5	13	31	11.8	0.1	1	31.3	90.9	6.8787	71.5797
2025	10	12	5	23	31	11.8	0.1	1	30.47	93.8	6.8787	69.5215
2025	10	12	5	33	31	11.8	0.1	1	31.18	94.2	6.8848	71.188
2025	10	12	5	43	31	11.8	0.1	1	30.91	91.7	6.8848	70.7302
2025	10	12	5	53	31	11.8	0.1	1	30.65	93.4	6.8848	70.0435
2025	10	12	6	3	31	11.8	0.1	1	30.11	91.3	6.8787	68.8355
2025	10	12	6	13	31	11.8	0.1	1	31.64	92.7	6.8787	72.2659
2025	10	12	6	23	31	11.8	0.1	1	30.85	93.2	6.8787	70.4364
2025	10	12	6	33	31	11.8	0.1	1	30.45	93.2	6.8787	69.5217
2025	10	12	6	43	31	11.8	0.1	1	31.04	93	6.8787	70.8938
2025	10	12	6	53	31	11.8	0.1	1	31.13	92.6	6.8787	71.1226
2025	10	12	7	3	31	11.8	0.1	1	31.42	91.8	6.8787	71.8086
2025	10	12	7	13	31	11.8	0.1	1	30.8	94.7	6.8787	70.2078
2025	10	12	7	23	31	11.8	0.1	1	31.22	91.8	6.8787	71.3513
2025	10	12	7	33	31	11.8	0.1	1	29.92	92.3	6.8787	68.3784
2025	10	12	7	43	31	12	0.1	1	31.94	92.7	6.8787	72.9522
2025	10	12	7	53	31	12.2	0.1	1	31.13	92.6	6.8787	71.1227

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	12	8	3	31	12.6	0.1	1	31.8	94.5	6.8787	72.4949
2025	10	12	8	13	31	12.8	0.1	1	31.2	94.6	6.8787	71.1228
2025	10	12	8	23	31	12.8	0.1	1	31.76	93.6	6.8787	72.4949
2025	10	12	8	33	31	12.8	0.1	1	30.73	92.6	6.8787	70.208
2025	10	12	8	43	31	12.8	0.1	1	31.15	93.1	6.8787	71.1228
2025	10	12	8	53	31	12.8	0.1	1	31.58	94	6.8787	72.0376
2025	10	12	9	3	31	13	0.1	1	32.12	92.1	6.8787	73.4097
2025	10	12	9	13	31	13	0.1	1	31.96	93.4	6.8787	72.9523
2025	10	12	9	23	31	13	0.1	1	30.77	93.9	6.8787	70.208
2025	10	12	9	33	31	13	0.1	1	30.42	91.9	6.8787	69.5219
2025	10	12	9	43	31	13	0.1	1	31.47	96	6.8787	71.5802
2025	10	12	9	53	31	13.4	0.1	1	32.07	93.8	6.8787	73.181
2025	10	12	10	3	31	13.6	0.1	1	31.6	94.5	6.8848	72.104
2025	10	12	10	13	31	13.6	0.1	1	31.02	92.2	6.8848	70.9594
2025	10	12	10	23	31	13.8	0.1	1	30.83	92.6	6.8848	70.5016
2025	10	12	10	33	31	13.8	0.1	1	32.02	92	6.8848	73.2484
2025	10	12	10	43	31	13.8	0.1	1	30.51	91.5	6.8848	69.8148
2025	10	12	10	53	31	13.8	0.1	1	30.82	92	6.8848	70.5015
2025	10	12	11	3	31	13.8	0.1	1	31.63	92.4	6.8848	72.3326
2025	10	12	11	13	31	13.8	0.1	1	31.13	92.4	6.8848	71.1881
2025	10	12	11	23	31	13.6	0.1	1	31.02	92.2	6.8848	70.9591
2025	10	12	11	33	31	13.8	0.1	1	31.75	93.1	6.8848	72.5614
2025	10	12	11	43	31	13.8	0.1	1	30.93	92.6	6.8848	70.7301
2025	10	12	11	53	31	13.8	0.1	1	32.43	92.3	6.8848	74.1636
2025	10	12	12	3	31	13.8	0.1	1	31.4	94.6	6.8848	71.6456
2025	10	12	12	13	31	13.8	0.1	1	31.77	93.8	6.8848	72.5612
2025	10	12	12	23	31	13.8	0.1	1	30.79	94.5	6.8848	70.2721
2025	10	12	12	33	31	13.8	0.1	1	31.88	94	6.8848	72.79
2025	10	12	12	43	31	13.8	0.1	1	31.47	93.8	6.8848	71.8743
2025	10	12	12	53	31	13.8	0.1	1	31.04	93	6.8848	70.9587
2025	10	12	13	3	31	13.8	0.1	1	32	94.5	6.8848	73.0187
2025	10	12	13	13	31	13.8	0.1	1	31.34	92.9	6.8848	71.6453
2025	10	12	13	23	31	13.8	0.1	1	30.78	94.1	6.8848	70.2718
2025	10	12	13	33	31	13.6	0.1	1	31.16	93.7	6.8848	71.1874
2025	10	12	13	43	31	13.4	0.1	1	29.93	92.5	6.8848	68.4406
2025	10	12	13	53	31	13.4	0.1	1	31.24	92.8	6.8848	71.4162
2025	10	12	14	3	31	13.4	0.1	1	32.12	92.1	6.8848	73.4762
2025	10	12	14	13	31	13.4	0.1	1	31.36	93.7	6.8848	71.645
2025	10	12	14	23	31	13.4	0.1	1	32.23	92.3	6.8787	73.6371
2025	10	12	14	33	31	13.4	0.1	1	31.51	91.5	6.8787	72.0362
2025	10	12	14	43	31	13.4	0.1	1	31.12	92	6.8787	71.1215
2025	10	12	14	53	31	13.4	0.1	1	31.77	93.8	6.8787	72.4936
2025	10	12	15	3	31	13.4	0.1	1	31.07	93.9	6.8787	70.8927
2025	10	12	15	13	31	13.4	0.1	1	30.87	93.9	6.8787	70.4353
2025	10	12	15	23	31	13.2	0.1	1	31.74	92.7	6.8787	72.4935
2025	10	12	15	33	31	13.2	0.1	1	31.41	94.7	6.8726	71.5126
2025	10	12	15	43	31	13.2	0.1	1	31.14	92.9	6.8726	71.0557
2025	10	12	15	53	31	13.2	0.1	1	31.07	93.9	6.8726	70.8272

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	12	16	3	31	13.2	0.1	1	31.23	92.4	6.8726	71.2841
2025	10	12	16	13	31	13.2	0.1	1	32.47	93.7	6.8726	74.0258
2025	10	12	16	23	31	13.4	0.1	1	30.23	92.5	6.8665	68.9356
2025	10	12	16	33	31	13.4	0.1	1	31.82	92.2	6.8726	72.655
2025	10	12	16	43	31	13.4	0.1	1	31.87	93.8	6.8726	72.655
2025	10	12	16	53	31	13.4	0.1	1	30.45	93.2	6.8665	69.3922
2025	10	12	17	3	31	13.4	0.1	1	30.97	93.9	6.8665	70.5335
2025	10	12	17	13	31	13.4	0.1	1	31.38	94	6.8665	71.4466
2025	10	12	17	23	31	13.4	0.1	1	30.45	93.4	6.8665	69.3922
2025	10	12	17	33	31	12.8	0.1	1	30.95	93.3	6.8604	70.4683
2025	10	12	17	43	31	12.2	0.1	1	31.12	92	6.8726	71.0557
2025	10	12	17	53	31	12.2	0.1	1	31.35	93.3	6.8726	71.5126
2025	10	12	18	3	31	12.2	0.1	1	31.63	92.4	6.8726	72.1981
2025	10	12	18	13	31	12.2	0.1	1	30.61	91.5	6.8726	69.9134
2025	10	12	18	23	31	12.2	0.1	1	32.33	92.3	6.8726	73.7975
2025	10	12	18	33	31	12.2	0.1	1	29.46	93.5	6.8665	67.1097
2025	10	12	18	43	31	12.2	0.1	1	30.91	91.5	6.8726	70.5989
2025	10	12	18	53	31	12.2	0.1	1	30.63	92.4	6.8726	69.9135
2025	10	12	19	3	31	12.2	0.1	1	31.07	93.9	6.8787	70.8928
2025	10	12	19	13	31	12.2	0.1	1	31.78	94	6.8787	72.4937
2025	10	12	19	23	31	12.2	0.1	1	30.94	93	6.8787	70.6642
2025	10	12	19	33	31	12.2	0.1	1	30.54	92.8	6.8726	69.6851
2025	10	12	19	43	31	12.2	0.1	1	31.7	94.5	6.8726	72.1984
2025	10	12	19	53	31	12.2	0.1	1	30.27	94	6.8726	68.9998
2025	10	12	20	3	31	12.2	0.1	1	30.43	92.4	6.8726	69.4568
2025	10	12	20	13	31	12	0.1	1	31.15	93.1	6.8726	71.0562
2025	10	12	20	23	31	12	0.1	1	30.01	91.7	6.8726	68.543
2025	10	12	20	33	31	12	0.1	1	31.84	92.7	6.8726	72.6556
2025	10	12	20	43	31	12	0.1	1	30.15	93.4	6.8726	68.7715
2025	10	12	20	53	31	12	0.1	1	31.33	92.4	6.8726	71.5133
2025	10	12	21	3	31	12	0.1	1	30.52	91.9	6.8726	69.6855
2025	10	12	21	13	31	12	0.1	1	31.34	92.9	6.8726	71.5134
2025	10	12	21	23	31	12	0.1	1	30.45	93.2	6.8726	69.4572
2025	10	12	21	33	31	12	0.1	1	30.25	93.2	6.8726	69.0002
2025	10	12	21	43	31	12	0.1	1	31.2	94.6	6.8726	71.0566
2025	10	12	21	53	31	12	0.1	1	30.72	92.1	6.8726	70.1427
2025	10	12	22	3	31	12	0.1	1	30.15	93.2	6.8726	68.7719
2025	10	12	22	13	31	12	0.1	1	30.52	92.1	6.8726	69.6859
2025	10	12	22	23	31	12	0.1	1	31.32	92.2	6.8726	71.5137
2025	10	12	22	33	31	12	0.1	1	31.92	91.8	6.8726	72.8846
2025	10	12	22	43	31	12	0.1	1	30.82	92.2	6.8726	70.3714
2025	10	12	22	53	31	12	0.1	1	31.26	93.7	6.8726	71.2854
2025	10	12	23	3	31	12	0.1	1	31.02	92.2	6.8726	70.8285
2025	10	12	23	13	31	12	0.1	1	31.11	91.7	6.8726	71.057
2025	10	12	23	23	31	12	0.1	1	30.76	93.5	6.8726	70.1431
2025	10	12	23	33	31	12	0.1	1	30.64	92.8	6.8726	69.9147
2025	10	12	23	43	31	12	0.1	1	31.15	93.1	6.8665	70.9915
2025	10	12	23	53	31	12	0.1	1	31.56	93.6	6.8665	71.9046

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	13	0	3	31	12	0.1	1	30.7	94.7	6.8726	69.9148
2025	10	13	0	13	31	12	0.1	1	30.6	90.9	6.8726	69.9148
2025	10	13	0	23	31	12	0.1	1	31.43	92.4	6.8726	71.7427
2025	10	13	0	33	31	12	0.1	1	31.08	94.1	6.8665	70.7634
2025	10	13	0	43	31	12	0.1	1	31.6	94.5	6.8665	71.9048
2025	10	13	0	53	31	12	0.1	1	31.44	92.9	6.8665	71.6766
2025	10	13	1	3	31	12	0.1	1	31.64	92.9	6.8665	72.1332
2025	10	13	1	13	31	12	0.1	1	32	94.5	6.8665	72.818
2025	10	13	1	23	31	12	0.1	1	31.49	94.4	6.8665	71.6767
2025	10	13	1	33	31	12	0.1	1	31.47	93.8	6.8665	71.6767
2025	10	13	1	43	31	12	0.1	1	30.53	92.4	6.8665	69.6223
2025	10	13	1	53	31	12	0.1	1	31.03	95.2	6.8665	70.5354
2025	10	13	2	3	31	12	0.1	1	31.41	91.6	6.8665	71.6768
2025	10	13	2	13	31	12	0.1	1	31.96	93.6	6.8665	72.8182
2025	10	13	2	23	31	12	0.1	1	29.47	94.1	6.8665	67.1115
2025	10	13	2	33	31	12	0.1	1	30.6	94.7	6.8665	69.6225
2025	10	13	2	43	31	12	0.1	1	31.36	93.5	6.8665	71.4487
2025	10	13	2	53	31	12	0.1	1	30.87	93.9	6.8665	70.3074
2025	10	13	3	3	31	12	0.1	1	30.69	94.5	6.8665	69.8508
2025	10	13	3	13	31	11.8	0.1	1	30.9	94.6	6.8665	70.3074
2025	10	13	3	23	31	11.8	0.1	1	30.86	93.5	6.8665	70.3074
2025	10	13	3	33	31	11.8	0.1	1	31.96	93.4	6.8665	72.8184
2025	10	13	3	43	31	11.8	0.1	1	30.93	92.6	6.8665	70.5358
2025	10	13	3	53	31	11.8	0.1	1	31.16	93.7	6.8665	70.9923
2025	10	13	4	3	31	11.8	0.1	1	30.83	92.6	6.8665	70.3075
2025	10	13	4	13	31	11.8	0.1	1	30.43	92.6	6.8665	69.3945
2025	10	13	4	23	31	11.8	0.1	1	31.22	91.8	6.8665	71.2207
2025	10	13	4	33	31	11.8	0.1	1	30.71	91.7	6.8665	70.0793
2025	10	13	4	43	31	11.8	0.1	1	30.75	93.2	6.8665	70.0794
2025	10	13	4	53	31	11.8	0.1	1	30.44	95.5	6.8665	69.1663
2025	10	13	5	3	31	11.8	0.1	1	30.8	94.7	6.8665	70.0794
2025	10	13	5	13	31	11.8	0.1	1	31.56	93.6	6.8665	71.9056
2025	10	13	5	23	31	11.8	0.1	1	30.39	94.3	6.8665	69.1664
2025	10	13	5	33	31	11.8	0.1	1	31.14	92.8	6.8665	70.9926
2025	10	13	5	43	31	11.8	0.1	1	31.66	93.6	6.8665	72.134
2025	10	13	5	53	31	11.8	0.1	1	30.94	93	6.8604	70.4709
2025	10	13	6	3	31	11.8	0.1	1	30.21	91.5	6.8665	68.9382
2025	10	13	6	13	31	11.8	0.1	1	31.24	92.9	6.8604	71.1551
2025	10	13	6	23	31	11.8	0.1	1	31.64	92.9	6.8604	72.0674
2025	10	13	6	33	31	11.8	0.1	1	30.44	93	6.8604	69.3307
2025	10	13	6	43	31	11.8	0.1	1	31.04	92.8	6.8604	70.699
2025	10	13	6	53	31	11.8	0.1	1	30.68	94.1	6.8665	69.8514
2025	10	13	7	3	31	11.8	0.1	1	32.22	91.8	6.8665	73.5038
2025	10	13	7	13	31	11.8	0.1	1	31.55	93.1	6.8604	71.8394
2025	10	13	7	23	31	11.8	0.1	1	29.82	91.9	6.8604	67.9624
2025	10	13	7	33	31	11.8	0.1	1	30.14	93	6.8604	68.6466
2025	10	13	7	43	31	11.8	0.1	1	31.9	94.5	6.8604	72.5237
2025	10	13	7	53	31	12.4	0.1	1	30.7	94.7	6.8604	69.787

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	13	8	3	31	12.6	0.1	1	30.99	94.3	6.8604	70.4712
2025	10	13	8	13	31	13	0.1	1	31.03	92.6	6.8604	70.6992
2025	10	13	8	23	31	13	0.1	1	30.51	91.7	6.8604	69.559
2025	10	13	8	33	31	13.2	0.1	1	31.84	92.9	6.8665	72.5909
2025	10	13	8	43	31	13.2	0.1	1	31.66	93.6	6.8665	72.1343
2025	10	13	8	53	31	13.2	0.1	1	30.57	93.8	6.8665	69.6233
2025	10	13	9	3	31	13.2	0.1	1	30.95	93.1	6.8665	70.5364
2025	10	13	9	13	31	13.4	0.1	1	30.35	93.4	6.8665	69.1668
2025	10	13	9	23	31	13.6	0.1	1	30.76	93.5	6.8665	70.0798
2025	10	13	9	33	31	13.6	0.1	1	30.6	94.7	6.8665	69.6233
2025	10	13	9	43	31	13.6	0.1	1	31.04	93	6.8665	70.7646
2025	10	13	9	53	31	13.8	0.1	1	29.96	93.6	6.8665	68.2536
2025	10	13	10	3	31	13.6	0.1	1	29.97	93.8	6.8665	68.2535
2025	10	13	10	13	31	13.6	0.1	1	30.87	93.9	6.8665	70.308
2025	10	13	10	23	31	13.4	0.1	1	31.37	93.8	6.8665	71.4493
2025	10	13	10	33	31	13.4	0.1	1	30.33	92.5	6.8665	69.1665
2025	10	13	10	43	31	13.4	0.1	1	29.85	93.3	6.8665	68.0251
2025	10	13	10	53	31	13.4	0.1	1	31.37	93.8	6.8665	71.4491
2025	10	13	11	3	31	13.4	0.1	1	30.24	93	6.8665	68.9381
2025	10	13	11	13	31	13.4	0.1	1	30.99	94.4	6.8665	70.536
2025	10	13	11	23	31	13.4	0.1	1	30.25	93.2	6.8665	68.938
2025	10	13	11	33	31	13.8	0.1	1	30.39	94.5	6.8665	69.1663
2025	10	13	11	43	31	13.4	0.1	1	30.84	95.4	6.8726	70.1441
2025	10	13	11	53	31	13.6	0.1	1	30.75	95.6	6.8726	69.9155
2025	10	13	12	3	31	14	0.1	1	31.35	95.7	6.8726	71.2864
2025	10	13	12	13	31	13.8	0.1	1	30.61	94.9	6.8726	69.6869
2025	10	13	12	23	31	14	0.1	1	29.97	93.8	6.8726	68.316
2025	10	13	12	33	31	14.2	0.1	1	30.68	94.1	6.8726	69.9153
2025	10	13	12	43	31	14.2	0.1	1	32.09	94.3	6.8726	73.114
2025	10	13	12	53	31	14.2	0.1	1	30.15	95.7	6.8726	68.5443
2025	10	13	13	3	31	14.2	0.1	1	30.79	94.3	6.8726	70.1436
2025	10	13	13	13	31	13.8	0.1	1	31.45	93.3	6.8726	71.743
2025	10	13	13	23	31	13.6	0.1	1	31.1	94.6	6.8726	70.829
2025	10	13	13	33	31	14	0.1	1	30.57	93.9	6.8726	69.6866
2025	10	13	13	43	31	13.8	0.1	1	31.3	94.6	6.8665	71.22
2025	10	13	13	53	31	14	0.1	1	30.57	93.9	6.8787	69.7508
2025	10	13	14	3	31	14.2	0.1	1	30.42	92.3	6.8726	69.4579
2025	10	13	14	13	31	14	0.1	1	31.12	92.2	6.8726	71.0573
2025	10	13	14	23	31	13.6	0.1	1	31.13	92.6	6.8604	70.926
2025	10	13	14	33	31	13.6	0.1	1	30.25	93.4	6.8665	68.9372
2025	10	13	14	43	31	13.2	0.1	1	31.6	94.5	6.8604	71.8382
2025	10	13	14	53	31	12.8	0.1	1	31.55	93.3	6.8665	71.9047
2025	10	13	15	3	31	12.4	0.1	1	30.77	93.9	6.8665	70.0785
2025	10	13	15	13	31	12.4	0.1	1	31.16	93.7	6.8665	70.9916
2025	10	13	15	23	31	12.4	0.1	1	30.67	93.7	6.8665	69.8502
2025	10	13	15	33	31	12.4	0.1	1	31.56	93.5	6.8604	71.8382
2025	10	13	15	43	31	12.2	0.1	1	31.06	93.7	6.8665	70.7633
2025	10	13	15	53	31	12.2	0.1	1	31.07	93.9	6.8665	70.7633

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	13	16	3	31	12.4	0.1	1	31.54	92.7	6.8665	71.9046
2025	10	13	16	13	31	12.4	0.1	1	31.66	93.4	6.8665	72.1329
2025	10	13	16	23	31	12.4	0.1	1	31.75	93.2	6.8665	72.3612
2025	10	13	16	33	31	12.4	0.1	1	31.13	92.4	6.8726	71.0572
2025	10	13	16	43	31	12.4	0.1	1	31.62	92.2	6.8726	72.1995
2025	10	13	16	53	31	12.4	0.1	1	31.06	93.7	6.8604	70.6978
2025	10	13	17	3	31	12.4	0.1	1	31.22	95	6.8665	70.9915
2025	10	13	17	13	31	12.4	0.1	1	31.51	91.3	6.8665	71.9046
2025	10	13	17	23	31	12.2	0.1	1	30.45	93.2	6.8726	69.4578
2025	10	13	17	33	31	12.2	0.1	1	31.68	94	6.8665	72.1329
2025	10	13	17	43	31	12.2	0.1	1	32.04	92.9	6.8726	73.1135
2025	10	13	17	53	31	12.2	0.1	1	30.41	91.5	6.8665	69.3937
2025	10	13	18	3	31	12.2	0.1	1	31.66	93.6	6.8665	72.1329
2025	10	13	18	13	31	12.2	0.1	1	30.75	93.2	6.8726	70.1433
2025	10	13	18	23	31	12.2	0.1	1	31.06	93.5	6.8665	70.7633
2025	10	13	18	33	31	12.2	0.1	1	30.25	93.2	6.8604	68.8735
2025	10	13	18	43	31	12.2	0.1	1	31.5	94.6	6.8665	71.6764
2025	10	13	18	53	31	12.2	0.1	1	31.6	94.5	6.8665	71.9047
2025	10	13	19	3	31	12.2	0.1	1	31.35	93.1	6.8665	71.4482
2025	10	13	19	13	31	12.2	0.1	1	31.27	93.9	6.8665	71.22
2025	10	13	19	23	31	12.2	0.1	1	31.43	92.4	6.8665	71.6765
2025	10	13	19	33	31	12.2	0.1	1	31.25	93.3	6.8604	71.1542
2025	10	13	19	43	31	12.2	0.1	1	30.65	93.2	6.8665	69.8504
2025	10	13	19	53	31	12	0.1	1	31.66	93.4	6.8726	72.1998
2025	10	13	20	3	31	12	0.1	1	31.07	93.9	6.8726	70.829
2025	10	13	20	13	31	12	0.1	1	31.53	92.4	6.8665	71.905
2025	10	13	20	23	31	12	0.1	1	31.83	92.3	6.8665	72.5898
2025	10	13	20	33	31	12	0.1	1	31	94.6	6.8604	70.4702
2025	10	13	20	43	31	12	0.1	1	31.05	93.3	6.8726	70.8291
2025	10	13	20	53	31	12	0.1	1	30.55	93.2	6.8665	69.6224
2025	10	13	21	3	31	12	0.1	1	31.41	94.7	6.8665	71.4485
2025	10	13	21	13	31	12	0.1	1	31.27	93.9	6.8665	71.2203
2025	10	13	21	23	31	12	0.1	1	32.14	92.9	6.8665	73.2747
2025	10	13	21	33	31	12	0.1	1	30.85	93.2	6.8665	70.3073
2025	10	13	21	43	31	12	0.1	1	30.55	93.4	6.8665	69.6225
2025	10	13	21	53	31	12	0.1	1	31.85	95.6	6.8665	72.3617
2025	10	13	22	3	31	12	0.1	1	31.85	93.2	6.8665	72.59
2025	10	13	22	13	31	12	0.1	1	31.73	92.3	6.8665	72.3618
2025	10	13	22	23	31	12	0.1	1	31.66	93.6	6.8726	72.2002
2025	10	13	22	33	31	12	0.1	1	30.9	94.6	6.8665	70.3074
2025	10	13	22	43	31	12	0.1	1	31.61	94.7	6.8665	71.9053
2025	10	13	22	53	31	12	0.1	1	30.82	92.2	6.8726	70.3724
2025	10	13	23	3	31	12	0.1	1	31.66	93.4	6.8726	72.2003
2025	10	13	23	13	31	12	0.1	1	31.85	93.2	6.8665	72.5902
2025	10	13	23	23	31	12	0.1	1	30.75	93.2	6.8787	70.2088
2025	10	13	23	33	31	12	0.1	1	31.71	94.7	6.8726	72.2003
2025	10	13	23	43	31	12	0.1	1	32.56	93.5	6.8726	74.2567
2025	10	13	23	53	31	12	0.1	1	30.54	92.8	6.8726	69.6871

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	14	0	3	31	12	0.1	1	30.54	92.8	6.8665	69.6227
2025	10	14	0	13	31	12	0.1	1	31.48	94	6.8604	71.6109
2025	10	14	0	23	31	12	0.1	1	31.61	94.7	6.8787	72.0384
2025	10	14	0	33	31	12	0.1	1	30	94.6	6.8665	68.2531
2025	10	14	0	43	31	12	0.1	1	29.9	94.8	6.8726	68.0878
2025	10	14	0	53	31	12	0.1	1	31.76	93.4	6.8665	72.362
2025	10	14	1	3	31	12	0.1	1	31.58	94.2	6.8726	71.972
2025	10	14	1	13	31	12	0.1	1	31.04	92.8	6.8726	70.8296
2025	10	14	1	23	31	12	0.1	1	30.91	91.7	6.8726	70.6011
2025	10	14	1	33	31	12	0.1	1	31.31	91.5	6.8726	71.515
2025	10	14	1	43	31	12	0.1	1	31.92	92	6.8665	72.8186
2025	10	14	1	53	31	12	0.1	1	31.26	93.5	6.8726	71.2865
2025	10	14	2	3	31	12	0.1	1	31.95	93.2	6.8665	72.8186
2025	10	14	2	13	31	12	0.1	1	32.32	95	6.8726	73.5714
2025	10	14	2	23	31	12	0.1	1	31.26	93.7	6.8665	71.2207
2025	10	14	2	33	31	12	0.1	1	31.01	91.5	6.8726	70.8296
2025	10	14	2	43	31	12	0.1	1	31.21	94.8	6.8665	70.9925
2025	10	14	2	53	31	12	0.1	1	31.86	93.6	6.8726	72.6575
2025	10	14	3	3	31	12	0.1	1	29.75	93.3	6.8726	67.8593
2025	10	14	3	13	31	12	0.1	1	31.11	94.8	6.8726	70.8296
2025	10	14	3	23	31	12	0.1	1	31.25	93.1	6.8787	71.3524
2025	10	14	3	33	31	12	0.1	1	31.28	94	6.8726	71.2866
2025	10	14	3	43	31	12	0.1	1	31.22	91.8	6.8787	71.3524
2025	10	14	3	53	31	12	0.1	1	31.89	94.3	6.8787	72.7245
2025	10	14	4	3	31	12	0.1	1	31.83	92.3	6.8787	72.7245
2025	10	14	4	13	31	11.8	0.1	1	31.25	93.3	6.8787	71.3524
2025	10	14	4	23	31	11.8	0.1	1	30.27	93.8	6.8787	69.0654
2025	10	14	4	33	31	11.8	0.1	1	30.81	91.7	6.8787	70.4376
2025	10	14	4	43	31	11.8	0.1	1	30.75	93.4	6.8787	70.2089
2025	10	14	4	53	31	11.8	0.1	1	30.35	93.4	6.8726	69.2302
2025	10	14	5	3	31	11.8	0.1	1	30.62	92.1	6.8726	69.9156
2025	10	14	5	13	31	11.8	0.1	1	30.86	93.7	6.8726	70.3726
2025	10	14	5	23	31	11.8	0.1	1	32.42	91.8	6.8726	74.0283
2025	10	14	5	33	31	11.8	0.1	1	32.05	93.2	6.8787	73.1819
2025	10	14	5	43	31	11.8	0.1	1	31.92	95	6.8787	72.7245
2025	10	14	5	53	31	11.8	0.1	1	31.19	94.4	6.8787	71.1237
2025	10	14	6	3	31	11.8	0.1	1	31.63	95.3	6.8787	72.0384
2025	10	14	6	13	31	11.8	0.1	1	31.44	92.9	6.8787	71.8097
2025	10	14	6	23	31	11.8	0.1	1	31.53	92.4	6.8787	72.0384
2025	10	14	6	33	31	11.8	0.1	1	31.54	92.9	6.8787	72.0385
2025	10	14	6	43	31	11.8	0.1	1	32.85	93.3	6.8787	75.0115
2025	10	14	6	53	31	11.8	0.1	1	31.16	93.7	6.8787	71.1237
2025	10	14	7	3	31	11.8	0.1	1	31.88	94.1	6.8787	72.7245
2025	10	14	7	13	31	11.8	0.1	1	31.59	94.4	6.8848	72.1049
2025	10	14	7	23	31	11.8	0.1	1	30.74	95.4	6.8848	70.0448
2025	10	14	7	33	31	11.8	0.1	1	32.03	92.3	6.8787	73.182
2025	10	14	7	43	31	11.8	0.1	1	30.85	93.3	6.8787	70.4376
2025	10	14	7	53	31	11.8	0.1	1	31.76	93.6	6.8787	72.4959

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	14	8	3	31	11.8	0.1	1	30.27	93.8	6.8848	69.1292
2025	10	14	8	13	31	11.8	0.1	1	32.28	93.9	6.8848	73.7073
2025	10	14	8	23	31	11.8	0.1	1	31.69	96.3	6.8909	72.1715
2025	10	14	8	33	31	11.8	0.1	1	31.26	93.5	6.8848	71.4183
2025	10	14	8	43	31	11.8	0.1	1	31.59	94.4	6.8848	72.105
2025	10	14	8	53	31	11.8	0.1	1	31.54	92.9	6.8848	72.105
2025	10	14	9	3	31	11.8	0.1	1	30.39	94.5	6.8787	69.2942
2025	10	14	9	13	31	11.8	0.1	1	31.14	92.8	6.8848	71.1894
2025	10	14	9	23	31	11.8	0.1	1	31.86	93.6	6.8848	72.7918
2025	10	14	9	33	31	11.8	0.1	1	30.92	92.2	6.8848	70.7316
2025	10	14	9	43	31	11.8	0.1	1	31.21	94.8	6.8848	71.1894
2025	10	14	9	53	31	11.8	0.1	1	30.86	93.7	6.8848	70.5027
2025	10	14	10	3	31	11.8	0.1	1	31.93	92.5	6.8909	73.088
2025	10	14	10	13	31	11.8	0.1	1	30.74	93	6.8909	70.3386
2025	10	14	10	23	31	11.8	0.1	1	31.46	93.5	6.8909	71.9424
2025	10	14	10	33	31	11.8	0.1	1	31.39	94.4	6.897	71.7794
2025	10	14	10	43	31	11.8	0.1	1	31.89	96.3	6.897	72.6967
2025	10	14	10	53	31	11.8	0.1	1	30.66	93.6	6.897	70.1741
2025	10	14	11	3	31	12	0.1	1	30.98	94.1	6.897	70.8621
2025	10	14	11	13	31	12.2	0.1	1	31.05	93.3	6.9031	71.1568
2025	10	14	11	23	31	12.2	0.1	1	31.09	94.2	6.9031	71.1568
2025	10	14	11	33	31	12	0.1	1	30.87	93.9	6.9031	70.6978
2025	10	14	11	43	31	12	0.1	1	31.87	93.8	6.9092	73.0602
2025	10	14	11	53	31	12	0.1	1	31.13	92.4	6.9092	71.452
2025	10	14	12	3	31	12	0.1	1	31.26	93.5	6.9031	71.6159
2025	10	14	12	13	31	11.8	0.1	1	31.52	92.2	6.9092	72.371
2025	10	14	12	23	31	11.8	0.1	1	31.72	92.2	6.9153	72.8974
2025	10	14	12	33	31	11.8	0.1	1	30.26	93.6	6.9153	69.448
2025	10	14	12	43	31	11.8	0.1	1	31.13	92.4	6.9214	71.5833
2025	10	14	12	53	31	11.8	0.1	1	30.76	93.5	6.9214	70.6626
2025	10	14	13	3	31	11.8	0.1	1	32.33	92.5	6.9275	74.4136
2025	10	14	13	13	31	11.8	0.1	1	31.67	93.8	6.9275	72.8009
2025	10	14	13	23	31	11.8	0.1	1	32.12	91.8	6.9275	73.9528
2025	10	14	13	33	31	11.8	0.1	1	31.51	91.5	6.9275	72.5705
2025	10	14	13	43	31	11.8	0.1	1	32.37	93.9	6.9275	74.4136
2025	10	14	13	53	31	11.8	0.1	1	30.96	93.7	6.9275	71.1883
2025	10	14	14	3	31	11.8	0.1	1	31.92	95	6.9275	73.2617
2025	10	14	14	13	31	11.8	0.1	1	31.75	93.1	6.9275	73.0314
2025	10	14	14	23	31	11.8	0.1	1	32.03	92.5	6.9275	73.7225
2025	10	14	14	33	31	12.2	0.1	1	32.03	92.5	6.9214	73.655
2025	10	14	14	43	31	13.6	0.1	1	31.44	92.7	6.9275	72.3402
2025	10	14	14	53	31	13.6	0.1	1	32.35	93.2	6.9275	74.4136
2025	10	14	15	3	31	13.2	0.1	1	31.25	93.1	6.9214	71.8136
2025	10	14	15	13	31	13.4	0.1	1	32.34	92.8	6.9336	74.4818
2025	10	14	15	23	31	12	0.1	1	31.65	93.3	6.9275	72.801
2025	10	14	15	33	31	12	0.1	1	32.39	94.2	6.9275	74.4137
2025	10	14	15	43	31	13.2	0.1	1	32.43	92.3	6.9336	74.7124
2025	10	14	15	53	31	13.4	0.1	1	31.9	94.5	6.9275	73.2617

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	14	16	3	31	13.6	0.1	1	31.13	92.4	6.9153	71.5177
2025	10	14	16	13	31	13.4	0.1	1	32.72	92.1	6.9275	75.3351
2025	10	14	16	23	31	13.2	0.1	1	31.46	93.5	6.9214	72.2739
2025	10	14	16	33	31	14	0.1	1	30.81	91.3	6.9275	70.9579
2025	10	14	16	43	31	14	0.1	1	31.56	93.6	6.9275	72.5706
2025	10	14	16	53	31	13.8	0.1	1	31.64	92.9	6.9153	72.6676
2025	10	14	17	3	31	13.6	0.1	1	32.22	92	6.9214	74.1153
2025	10	14	17	13	31	13	0.1	1	30.52	92.3	6.9214	70.2024
2025	10	14	17	23	31	12.4	0.1	1	30.67	93.7	6.9214	70.4326
2025	10	14	17	33	31	12.2	0.1	1	31.54	92.9	6.9214	72.5042
2025	10	14	17	43	31	12.2	0.1	1	33.25	95.5	6.9214	76.187
2025	10	14	17	53	31	12.2	0.1	1	30.42	92.1	6.9275	70.0365
2025	10	14	18	3	31	12.2	0.1	1	32.26	93.6	6.9214	74.1155
2025	10	14	18	13	31	12.2	0.1	1	31.62	92.2	6.9153	72.6678
2025	10	14	18	23	31	12.2	0.1	1	31.06	93.7	6.9153	71.2881
2025	10	14	18	33	31	12.2	0.1	1	31.63	92.4	6.9214	72.7346
2025	10	14	18	43	31	12.2	0.1	1	31.35	93.1	6.9214	72.0441
2025	10	14	18	53	31	12.2	0.1	1	32.13	95.2	6.9214	73.6553
2025	10	14	19	3	31	12	0.1	1	31.29	94.4	6.9275	71.8798
2025	10	14	19	13	31	12	0.1	1	31.63	92.4	6.9214	72.7347
2025	10	14	19	23	31	12	0.1	1	31.44	92.9	6.9153	72.2081
2025	10	14	19	33	31	12	0.1	1	31.28	94.2	6.9214	71.814
2025	10	14	19	43	31	12	0.1	1	31.33	95.3	6.9214	71.8141
2025	10	14	19	53	31	12	0.1	1	32.21	94.8	6.9214	73.8857
2025	10	14	20	3	31	12	0.1	1	31.91	94.9	6.9214	73.1952
2025	10	14	20	13	31	12	0.1	1	31.64	92.9	6.9214	72.7348
2025	10	14	20	23	31	12	0.1	1	31.28	94.2	6.9214	71.8142
2025	10	14	20	33	31	12	0.1	1	31.28	94	6.9214	71.8142
2025	10	14	20	43	31	12	0.1	1	31.69	94.3	6.9214	72.7349
2025	10	14	20	53	31	12	0.1	1	31.76	93.6	6.9214	72.9651
2025	10	14	21	3	31	12	0.1	1	32.47	93.7	6.9214	74.5763
2025	10	14	21	13	31	12	0.1	1	31.15	93.3	6.9214	71.5841
2025	10	14	21	23	31	12	0.1	1	30.77	93.7	6.9214	70.6634
2025	10	14	21	33	31	12	0.1	1	31.92	91.8	6.9214	73.4255
2025	10	14	21	43	31	12	0.1	1	30.86	93.7	6.9214	70.8936
2025	10	14	21	53	31	12	0.1	1	31.6	94.5	6.9214	72.5049
2025	10	14	22	3	31	12	0.1	1	31.34	92.9	6.9214	72.0445
2025	10	14	22	13	31	12	0.1	1	31.45	93.3	6.9153	72.2085
2025	10	14	22	23	31	11.8	0.1	1	30.95	93.3	6.9153	71.0586
2025	10	14	22	33	31	11.8	0.1	1	31.42	94.9	6.9214	72.0446
2025	10	14	22	43	31	11.8	0.1	1	31.51	94.7	6.9214	72.2748
2025	10	14	22	53	31	11.8	0.1	1	30.45	93.4	6.9214	69.973
2025	10	14	23	3	31	11.8	0.1	1	31.13	92.4	6.9214	71.5843
2025	10	14	23	13	31	11.8	0.1	1	30.42	95.1	6.9214	69.7429
2025	10	14	23	23	31	11.8	0.1	1	31.05	93.1	6.9214	71.3541
2025	10	14	23	33	31	11.8	0.1	1	31.82	92.2	6.9214	73.1955
2025	10	14	23	43	31	11.8	0.1	1	30.72	92.2	6.9214	70.6636
2025	10	14	23	53	31	11.8	0.1	1	30.89	94.5	6.9214	70.8938

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	15	0	3	31	11.8	0.1	1	31.46	95.8	6.9214	72.0447
2025	10	15	0	13	31	11.8	0.1	1	30.84	93	6.9214	70.8938
2025	10	15	0	23	31	11.8	0.1	1	31.68	94	6.9214	72.7353
2025	10	15	0	33	31	11.8	0.1	1	30.95	93.3	6.9214	71.124
2025	10	15	0	43	31	11.8	0.1	1	30.73	92.4	6.9214	70.6637
2025	10	15	0	53	31	11.6	0.1	1	32.44	93	6.9214	74.5767
2025	10	15	1	3	31	11.6	0.1	1	31.87	93.8	6.9214	73.1957
2025	10	15	1	13	31	11.6	0.1	1	31.16	93.7	6.9214	71.5845
2025	10	15	1	23	31	11.6	0.1	1	32.12	92.1	6.9214	73.8863
2025	10	15	1	33	31	11.6	0.1	1	31.39	94.4	6.9214	72.0449
2025	10	15	1	43	31	11.6	0.1	1	31.04	92.8	6.9214	71.3544
2025	10	15	1	53	31	11.6	0.1	1	30.59	94.3	6.9214	70.2035
2025	10	15	2	3	31	11.6	0.1	1	32.24	93	6.9214	74.1165
2025	10	15	2	13	31	11.6	0.1	1	31.85	93.2	6.9214	73.1959
2025	10	15	2	23	31	11.6	0.1	1	30.61	91.7	6.9214	70.4338
2025	10	15	2	33	31	11.6	0.1	1	30.64	93	6.9214	70.4338
2025	10	15	2	43	31	11.6	0.1	1	32.03	92.3	6.9214	73.6563
2025	10	15	2	53	31	11.6	0.1	1	31.41	94.7	6.9214	72.0451
2025	10	15	3	3	31	11.6	0.1	1	31.96	93.6	6.9214	73.4261
2025	10	15	3	13	31	11.6	0.1	1	32.03	92.3	6.9275	73.7239
2025	10	15	3	23	31	11.6	0.1	1	31.03	92.4	6.9275	71.42
2025	10	15	3	33	31	11.6	0.1	1	31.24	92.8	6.9275	71.8808
2025	10	15	3	43	31	11.6	0.1	1	31.84	92.9	6.9275	73.2632
2025	10	15	3	53	31	11.6	0.1	1	31.04	93	6.9275	71.4201
2025	10	15	4	3	31	11.6	0.1	1	30.43	92.4	6.9275	70.0378
2025	10	15	4	13	31	11.6	0.1	1	31.32	92.2	6.9275	72.1113
2025	10	15	4	23	31	11.6	0.1	1	30.54	92.8	6.9336	70.3326
2025	10	15	4	33	31	11.6	0.1	1	30.93	92.6	6.9336	71.255
2025	10	15	4	43	31	11.6	0.1	1	31.41	94.7	6.9336	72.1774
2025	10	15	4	53	31	11.6	0.1	1	30.47	94	6.9397	70.1662
2025	10	15	5	3	31	11.6	0.1	1	31.24	92.9	6.9458	72.0786
2025	10	15	5	13	31	11.6	0.1	1	31.24	92.9	6.9458	72.0786
2025	10	15	5	23	31	11.6	0.1	1	30.27	93.8	6.9519	69.8321
2025	10	15	5	33	31	11.6	0.1	1	31.64	92.7	6.9519	73.0694
2025	10	15	5	43	31	11.6	0.1	1	31.61	94.7	6.9519	72.8382
2025	10	15	5	53	31	11.6	0.1	1	31.56	93.5	6.9519	72.8382
2025	10	15	6	3	31	11.6	0.1	1	32.4	94.6	6.9519	74.6881
2025	10	15	6	13	31	11.6	0.1	1	31.52	92	6.9519	72.8383
2025	10	15	6	23	31	11.6	0.1	1	31.65	93.3	6.9519	73.0696
2025	10	15	6	33	31	11.6	0.1	1	30.94	93	6.958	71.5162
2025	10	15	6	43	31	11.6	0.1	1	31.26	93.5	6.958	72.2105
2025	10	15	6	53	31	11.6	0.1	1	31.86	93.6	6.958	73.5992
2025	10	15	7	3	31	11.6	0.1	1	31.89	94.3	6.958	73.5993
2025	10	15	7	13	31	11.6	0.1	1	31.05	93.3	6.958	71.7477
2025	10	15	7	23	31	11.6	0.1	1	32.26	93.6	6.958	74.5251
2025	10	15	7	33	31	11.6	0.1	1	32.23	92.5	6.958	74.5251
2025	10	15	7	43	31	11.6	0.1	1	32.36	93.4	6.958	74.7566
2025	10	15	7	53	31	12	0.1	1	31.48	94.2	6.958	72.6736

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	15	8	3	31	12.2	0.1	1	32.9	94.4	6.958	75.9139
2025	10	15	8	13	31	12.4	0.1	1	32.56	93.3	6.958	75.2196
2025	10	15	8	23	31	12.8	0.1	1	30.84	93	6.9641	71.35
2025	10	15	8	40	0	13	0.1	1	32.11	94.8	6.9641	74.1299
2025	10	15	8	50	0	13.4	0.1	1	31.24	92.9	6.9641	72.2767
2025	10	15	9	0	0	13.4	0.1	1	31.09	94.2	6.9641	71.8134
2025	10	15	9	10	0	13.2	0.1	1	33.05	95.4	6.9641	76.2148
2025	10	15	9	20	0	13.4	0.1	1	31.07	93.9	6.9641	71.8134
2025	10	15	9	30	0	13.2	0.1	1	31.06	93.5	6.9641	71.8133
2025	10	15	9	40	0	13.8	0.1	1	31.91	91.4	6.9641	73.8982
2025	10	15	9	50	0	14.2	0.1	1	31.86	93.4	6.9641	73.6665
2025	10	15	10	0	0	14.2	0.1	1	30.22	92.3	6.9641	69.96
2025	10	15	10	10	0	14.2	0.1	1	30.87	93.9	6.9702	71.415
2025	10	15	10	20	0	14.2	0.1	1	31.81	91.4	6.9702	73.7336
2025	10	15	10	30	0	14.2	0.1	1	31.15	93.3	6.9702	72.1105
2025	10	15	10	40	0	14.2	0.1	1	31.84	92.7	6.9702	73.7335
2025	10	15	10	50	0	14.2	0.1	1	30.96	93.5	6.9702	71.6467
2025	10	15	11	0	0	14.2	0.1	1	32.17	95.9	6.9702	74.1972
2025	10	15	11	10	0	14.2	0.1	1	32.52	91.9	6.9702	75.3564
2025	10	15	11	20	0	14.2	0.1	1	32.45	93.2	6.9702	75.1245
2025	10	15	11	30	0	14.2	0.1	1	30.96	93.7	6.9702	71.6465
2025	10	15	11	40	0	14.2	0.1	1	30.85	93.3	6.9763	71.4795
2025	10	15	11	50	0	14.2	0.1	1	31.37	93.8	6.9763	72.6399
2025	10	15	12	0	0	14.2	0.1	1	31.66	93.4	6.9763	73.336
2025	10	15	12	10	0	14.2	0.1	1	30.83	92.4	6.9763	71.4794
2025	10	15	12	20	0	14.2	0.1	1	31.26	93.7	6.9763	72.4076
2025	10	15	12	30	0	14.2	0.1	1	31.22	91.8	6.9763	72.4076
2025	10	15	12	40	0	14.2	0.1	1	31.25	93.3	6.9763	72.4075
2025	10	15	12	50	0	14.2	0.1	1	31.81	94.7	6.9824	73.6347
2025	10	15	13	0	0	14.2	0.1	1	30.94	93	6.9824	71.7764
2025	10	15	13	10	0	14.2	0.1	1	31.95	93.1	6.9824	74.0992
2025	10	15	13	20	0	14.2	0.1	1	31.55	93.3	6.9824	73.17
2025	10	15	13	30	0	14.2	0.1	1	31.77	93.8	6.9824	73.6345
2025	10	15	13	40	0	14.2	0.1	1	31.13	92.6	6.9824	72.2407
2025	10	15	13	50	0	14.2	0.1	1	31.86	93.4	6.9824	73.8666
2025	10	15	14	0	0	14.2	0.1	1.1	31.83	92.5	6.9885	73.9337
2025	10	15	14	10	0	14.2	0.1	1.1	32.14	93	6.9885	74.6311
2025	10	15	14	20	0	14.2	0.1	1.1	31.24	92.8	6.9885	72.5386
2025	10	15	14	30	0	14.2	0.1	1.1	31.83	95.2	6.9885	73.701
2025	10	15	14	40	0	14.2	0.1	1.1	31.53	92.5	6.9885	73.236
2025	10	15	14	50	0	14.2	0.1	1.1	30.96	93.7	6.9885	71.841
2025	10	15	15	0	0	14.2	0.1	1.1	30.88	94.1	6.9885	71.6084
2025	10	15	15	10	0	14.2	0.1	1.1	31.65	93.1	6.9885	73.4683
2025	10	15	15	20	0	13.4	0.1	1.1	32.01	94.7	6.9885	74.1658
2025	10	15	15	30	0	13.4	0.1	1.1	32.87	93.8	6.9945	76.3274
2025	10	15	15	40	0	13.4	0.1	1.1	31.32	92.2	6.9945	72.8368
2025	10	15	15	50	0	13.4	0.1	1.1	32.53	92.6	6.9945	75.6292
2025	10	15	16	0	0	13.4	0.1	1.1	32.59	94.2	6.9945	75.6292

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	15	16	10	0	13.4	0.1	1.1	32.42	92.1	6.9945	75.3964
2025	10	15	16	20	0	13.4	0.1	1.1	32.16	93.4	6.9945	74.6983
2025	10	15	16	30	0	13.4	0.1	1.1	31.95	93.2	6.9945	74.2329
2025	10	15	16	40	0	13.4	0.1	1.1	31.76	93.6	6.9945	73.7675
2025	10	15	16	50	0	13.4	0.1	1.1	32.06	93.4	6.9945	74.4655
2025	10	15	17	0	0	13.2	0.1	1.1	30.72	92.2	6.9945	71.4404
2025	10	15	17	10	0	13	0.1	1.1	31.88	94	6.9945	74.0001
2025	10	15	17	20	0	12.8	0.1	1.1	32.84	93	6.9945	76.3271
2025	10	15	17	30	0	12.6	0.1	1.1	31.45	93.3	6.9945	73.0693
2025	10	15	17	40	0	12.4	0.1	1.1	31.94	92.9	6.9945	74.2328
2025	10	15	17	50	0	12.2	0.1	1.1	32.78	94	7.0006	76.1635
2025	10	15	18	0	0	12.2	0.1	1.1	31.91	94.9	7.0006	74.0673
2025	10	15	18	10	0	12.2	0.1	1.1	32.52	94.9	7.0006	75.4648
2025	10	15	18	20	0	12.2	0.1	1.1	32.24	92.8	7.0006	74.9989
2025	10	15	18	30	0	12.2	0.1	1.1	31.76	93.6	7.0006	73.8344
2025	10	15	18	40	0	12.2	0.1	1.1	31.34	92.7	7.0006	72.9027
2025	10	15	18	50	0	12.2	0.1	1.1	32.83	92.4	7.0006	76.3965
2025	10	15	19	0	0	12.2	0.1	1.1	32.14	92.9	7.0006	74.7661
2025	10	15	19	10	0	12.2	0.1	1.1	32.43	92.3	7.0006	75.4649
2025	10	15	19	20	0	12.2	0.1	1.1	32.69	94.2	7.0006	75.9308
2025	10	15	19	30	0	12.2	0.1	1.1	31.32	92.2	7.0006	72.9029
2025	10	15	19	40	0	12.2	0.1	1.1	31.32	92.2	7.0006	72.9029
2025	10	15	19	50	0	12.2	0.1	1.1	33.66	93.4	7.0006	78.26
2025	10	15	20	0	0	12.2	0.1	1.1	31.64	92.9	7.0006	73.6017
2025	10	15	20	10	0	12.2	0.1	1.1	31.28	94	7.0006	72.6701
2025	10	15	20	20	0	12.2	0.1	1.1	32.71	94.7	7.0006	75.931
2025	10	15	20	30	0	12	0.1	1.1	32.16	93.4	7.0006	74.7665
2025	10	15	20	40	0	12	0.1	1.1	32.04	92.7	7.0067	74.6011
2025	10	15	20	50	0	12	0.1	1.1	31.19	94.4	7.0067	72.503
2025	10	15	21	0	0	12	0.1	1.1	32.79	94.2	7.0067	76.2331
2025	10	15	21	10	0	12	0.1	1.1	31.56	93.6	7.0067	73.4356
2025	10	15	21	20	0	12	0.1	1.1	32.6	94.6	7.0067	75.7669
2025	10	15	21	30	0	12	0.1	1.1	32.81	96.5	7.0067	76.0001
2025	10	15	21	40	0	12	0.1	1.1	32.26	93.6	7.0067	75.0676
2025	10	15	21	50	0	12	0.1	1.1	32.23	92.3	7.0067	75.0677
2025	10	15	22	0	0	12	0.1	1.1	31.84	92.9	7.0128	74.2023
2025	10	15	22	10	0	12	0.1	1.1	31.72	92	7.0189	74.0359
2025	10	15	22	20	0	12	0.1	1.1	32.3	94.6	7.0189	75.2037
2025	10	15	22	30	0	12	0.1	1.1	31.26	93.7	7.025	72.9341
2025	10	15	22	40	0	12	0.1	1.1	32.25	93.2	7.0311	75.3398
2025	10	15	22	50	0	12	0.1	1.1	32.12	92	7.0311	75.1058
2025	10	15	23	0	0	12	0.1	1.1	31.37	93.8	7.0311	73.2341
2025	10	15	23	10	0	12	0.1	1.1	31.76	93.6	7.0311	74.17
2025	10	15	23	20	0	12	0.1	1.1	32.68	94	7.0311	76.2758
2025	10	15	23	30	0	12	0.1	1.1	32.44	92.8	7.0372	75.8763
2025	10	15	23	40	0	12	0.1	1.1	32.73	95.1	7.0372	76.3447
2025	10	15	23	50	0	12	0.1	1.1	32.28	93.9	7.0372	75.408
2025	10	16	0	0	0	12	0.1	1.1	33.14	92.8	7.0372	77.5158

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	16	0	10	0	12	0.1	1.1	33.51	91	7.0372	78.4525
2025	10	16	0	20	0	12	0.1	1.1	32.84	95.2	7.0372	76.5791
2025	10	16	0	30	0	12	0.1	1.1	31.98	93.9	7.0372	74.7056
2025	10	16	0	40	0	12	0.1	1.1	32.05	93	7.0372	74.9399
2025	10	16	0	50	0	12	0.1	1.1	32.67	93.7	7.0372	76.345
2025	10	16	1	0	0	12	0.1	1.1	32.47	93.7	7.0372	75.8767
2025	10	16	1	10	0	12	0.1	1.1	31.88	94.1	7.0372	74.4716
2025	10	16	1	20	0	12	0.1	1.1	31.76	93.6	7.0372	74.2374
2025	10	16	1	30	0	12	0.1	1.1	32.67	93.7	7.0372	76.3452
2025	10	16	1	40	0	12	0.1	1.1	31.34	92.9	7.0372	73.3008
2025	10	16	1	50	0	12	0.1	1.1	32.16	93.6	7.0372	75.1743
2025	10	16	2	0	0	12	0.1	1.1	32.16	93.6	7.0372	75.1743
2025	10	16	2	10	0	12	0.1	1.1	32.72	91.8	7.0372	76.5795
2025	10	16	2	20	0	12	0.1	1.1	32.52	92.1	7.0372	76.1111
2025	10	16	2	30	0	12	0.1	1.1	32.23	92.7	7.0372	75.4086
2025	10	16	2	40	0	12	0.1	1.1	32.46	93.5	7.0311	75.8086
2025	10	16	2	50	0	12	0.1	1.1	33.03	92.6	7.0372	77.2822
2025	10	16	3	0	0	12	0.1	1.1	32.19	94.3	7.0311	75.1067
2025	10	16	3	10	0	12	0.1	1.1	32.83	95.1	7.0311	76.5106
2025	10	16	3	20	0	12	0.1	1.1	32.3	94.6	7.0311	75.3408
2025	10	16	3	30	0	12	0.1	1.1	31.82	92	7.0311	74.4049
2025	10	16	3	40	0	12	0.1	1.1	32.76	93.5	7.0311	76.5107
2025	10	16	3	50	0	12	0.1	1.1	32.36	93.5	7.0311	75.5748
2025	10	16	4	0	0	12	0.1	1.1	32.6	94.6	7.0311	76.0428
2025	10	16	4	10	0	12	0.1	1.1	31.62	95.1	7.0311	73.703
2025	10	16	4	20	0	12	0.1	1.1	31.89	94.3	7.0311	74.405
2025	10	16	4	30	0	12	0.1	1.1	32.43	92.3	7.0311	75.8089
2025	10	16	4	40	0	12	0.1	1.1	32.14	92.7	7.0311	75.107
2025	10	16	4	50	0	12	0.1	1.1	33	94.5	7.025	76.9094
2025	10	16	5	0	0	12	0.1	1.1	32.56	93.3	7.025	75.9743
2025	10	16	5	10	0	12	0.1	1.1	32.96	93.5	7.025	76.9094
2025	10	16	5	20	0	12	0.1	1.1	32.56	93.5	7.025	75.9744
2025	10	16	5	30	0	12	0.1	1.1	32.09	94.3	7.025	74.8056
2025	10	16	5	40	0	11.8	0.1	1.1	32.27	93.7	7.025	75.2731
2025	10	16	5	50	0	11.8	0.1	1.1	32.53	92.3	7.025	75.9744
2025	10	16	6	0	0	11.8	0.1	1.1	32.04	92.9	7.025	74.8056
2025	10	16	6	10	0	11.8	0.1	1.1	32.23	92.3	7.025	75.2732
2025	10	16	6	20	0	11.8	0.1	1.1	32.37	93.9	7.0189	75.4388
2025	10	16	6	30	0	11.8	0.1	1.1	32.08	94.1	7.0189	74.7381
2025	10	16	6	40	0	11.8	0.1	1.1	32.66	93.5	7.0189	76.1395
2025	10	16	6	50	0	11.8	0.1	1.1	32.72	94.9	7.0189	76.1395
2025	10	16	7	0	0	11.8	0.1	1.1	33.18	94	7.0189	77.3073
2025	10	16	7	10	0	11.8	0.1	1.1	32.11	91.4	7.0128	74.904
2025	10	16	7	20	0	11.8	0.1	1.1	32.44	92.8	7.0128	75.6041
2025	10	16	7	30	0	11.8	0.1	1.1	33.35	93.1	7.0128	77.7042
2025	10	16	7	40	0	11.8	0.1	1.1	32.15	95.5	7.0128	74.6707
2025	10	16	7	50	0	12	0.1	1.1	32.48	94.1	7.0128	75.6041
2025	10	16	8	0	0	12.4	0.1	1.1	31.76	93.4	7.0128	73.9707

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	16	8	10	0	12.6	0.1	1.1	31.65	93.3	7.0067	73.6706
2025	10	16	8	20	0	12.8	0.1	1.1	32.07	93.8	7.0067	74.6032
2025	10	16	8	30	0	12.8	0.1	1.1	31.26	93.7	7.0067	72.7381
2025	10	16	8	40	0	13	0.1	1.1	32.36	93.4	7.0006	75.2344
2025	10	16	8	50	0	13	0.1	1.1	32.48	94.1	7.0006	75.4673
2025	10	16	9	0	0	13.2	0.1	1.1	32.46	93.4	7.0006	75.4673
2025	10	16	9	10	0	13.2	0.1	1.1	32.82	92.1	6.9945	76.3297
2025	10	16	9	20	0	13.2	0.1	1.1	32.16	93.4	6.9885	74.633
2025	10	16	9	30	0	13.2	0.1	1	31.91	94.9	6.9824	73.8683
2025	10	16	9	40	0	13.2	0.1	1	32.83	92.4	6.9824	76.1912
2025	10	16	9	50	0	13.4	0.1	1	31.38	94	6.9824	72.7068
2025	10	16	10	0	0	13.6	0.1	1	31.95	95.6	6.9824	73.8682
2025	10	16	10	10	0	13.6	0.1	1	31.33	92.6	6.9763	72.6406
2025	10	16	10	20	0	13.6	0.1	1	31.36	93.5	6.9763	72.6406
2025	10	16	10	30	0	13.6	0.1	1	30.34	92.8	6.9763	70.3198
2025	10	16	10	40	0	13.6	0.1	1	31.76	93.4	6.9763	73.5688
2025	10	16	10	50	0	13.6	0.1	1	31.24	92.9	6.9763	72.4083
2025	10	16	11	0	0	13.6	0.1	1	31.28	94	6.9763	72.4083
2025	10	16	11	10	0	13.6	0.1	1	31.32	91.8	6.9763	72.6403
2025	10	16	11	20	0	13.6	0.1	1	30.52	91.9	6.9763	70.7836
2025	10	16	11	30	0	13.6	0.1	1	30.85	93.3	6.9702	71.4147
2025	10	16	11	40	0	13.6	0.1	1	30.85	93.3	6.9763	71.4797
2025	10	16	11	50	0	13.6	0.1	1	30.84	93	6.9702	71.4146
2025	10	16	12	0	0	13.6	0.1	1	30.04	93.1	6.9702	69.5596
2025	10	16	12	10	0	13.6	0.1	1	32.02	95	6.9702	73.9649
2025	10	16	12	20	0	13.6	0.1	1	31.37	93.8	6.9702	72.5737
2025	10	16	12	30	0	13.6	0.1	1	31.46	93.6	6.9702	72.8055
2025	10	16	12	40	0	13.6	0.1	1	30.51	91.5	6.9702	70.7186
2025	10	16	12	50	0	13.6	0.1	1	30.33	92.6	6.9641	70.1908
2025	10	16	13	0	0	13.6	0.1	1	32.33	92.7	6.9641	74.8238
2025	10	16	13	10	0	13.6	0.1	1	30.91	91.5	6.9641	71.5806
2025	10	16	13	20	0	13.6	0.1	1	31.15	93.3	6.9641	72.0438
2025	10	16	13	30	0	13.6	0.1	1	32.05	93.2	6.958	74.0611
2025	10	16	13	40	0	13.6	0.1	1	30.93	92.4	6.958	71.5152
2025	10	16	13	50	0	13.6	0.1	1	30.36	93.6	6.9458	69.9986
2025	10	16	14	0	0	13.6	0.1	1	29.93	92.7	6.9397	69.0113
2025	10	16	14	10	0	13.4	0.1	1	31.66	93.4	6.9397	72.935
2025	10	16	14	20	0	13.4	0.1	1	31.74	92.9	6.9397	73.1657
2025	10	16	14	30	0	13.4	0.1	1	30.95	93.3	6.9397	71.3192
2025	10	16	14	40	0	13.4	0.1	1	31.66	93.4	6.9336	72.8681
2025	10	16	14	50	0	13.4	0.1	1	31.01	91.7	6.9336	71.4845
2025	10	16	15	0	0	13.4	0.1	1	31.12	91.8	6.9336	71.715
2025	10	16	15	10	0	13.4	0.1	1	30.97	93.9	6.9336	71.2538
2025	10	16	15	20	0	13.4	0.1	1	31.36	93.7	6.9336	72.1761
2025	10	16	15	30	0	13.4	0.1	1	31.06	93.7	6.9336	71.4843
2025	10	16	15	40	0	13.4	0.1	1	31.18	94.2	6.9336	71.7148
2025	10	16	15	50	0	13.4	0.1	1	31.34	92.7	6.9275	72.1099
2025	10	16	16	0	0	13.4	0.1	1	30.83	92.4	6.9275	70.958

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	16	16	10	0	13.4	0.1	1	30.93	92.4	6.9275	71.1883
2025	10	16	16	20	0	13.4	0.1	1	31.34	92.9	6.9275	72.1098
2025	10	16	16	30	0	13.4	0.1	1	30.7	94.7	6.9275	70.4971
2025	10	16	16	40	0	13.4	0.1	1	31.14	92.9	6.9275	71.649
2025	10	16	16	50	0	13.4	0.1	1	32.02	92	6.9275	73.7224
2025	10	16	17	0	0	13.4	0.1	1	31.64	92.9	6.9275	72.8009
2025	10	16	17	10	0	13.4	0.1	1	30.99	94.4	6.9275	71.1882
2025	10	16	17	20	0	13.4	0.1	1	31.26	93.7	6.9275	71.8793
2025	10	16	17	30	0	12.8	0.1	1	30.35	93.4	6.9214	69.7419
2025	10	16	17	40	0	12.2	0.1	1	31.46	93.5	6.9214	72.2738
2025	10	16	17	50	0	12.2	0.1	1	31.05	93.1	6.9214	71.3531
2025	10	16	18	0	0	12.2	0.1	1	30.86	93.7	6.9214	70.8928
2025	10	16	18	10	0	12.2	0.1	1	30.46	93.6	6.9214	69.9721
2025	10	16	18	20	0	12.2	0.1	1	31.24	92.9	6.9214	71.8135
2025	10	16	18	30	0	12.2	0.1	1	31.35	93.3	6.9214	72.0437
2025	10	16	18	40	0	12.2	0.1	1	31.44	92.9	6.9153	72.2076
2025	10	16	18	50	0	12.2	0.1	1	32.1	94.5	6.9214	73.6549
2025	10	16	19	0	0	12.2	0.1	1	30.07	93.8	6.9153	68.9882
2025	10	16	19	10	0	12.2	0.1	1	31.44	92.7	6.9153	72.2077
2025	10	16	19	20	0	12.2	0.1	1	30.17	94	6.9153	69.2182
2025	10	16	19	30	0	12.2	0.1	1	31.41	91.5	6.9153	72.2077
2025	10	16	19	40	0	12.2	0.1	1	31.06	93.7	6.9153	71.2879
2025	10	16	19	50	0	12.2	0.1	1	32.19	94.3	6.9153	73.8175
2025	10	16	20	0	0	12.2	0.1	1	31.79	94.3	6.9153	72.8977
2025	10	16	20	10	0	12	0.1	1	31.24	92.9	6.9153	71.7479
2025	10	16	20	20	0	12	0.1	1	31.55	93.1	6.9153	72.4378
2025	10	16	20	30	0	12	0.1	1	31.38	94	6.9153	71.9779
2025	10	16	20	40	0	12	0.1	1	30.2	90.8	6.9153	69.4484
2025	10	16	20	50	0	12	0.1	1	30.94	93	6.9153	71.0581
2025	10	16	21	0	0	12	0.1	1	30.62	92.2	6.9092	70.3037
2025	10	16	21	10	0	12	0.1	1	30.92	91.9	6.9092	70.993
2025	10	16	21	20	0	12	0.1	1	31.32	92.2	6.9092	71.912
2025	10	16	21	30	0	12	0.1	1	30.75	93.2	6.9092	70.5335
2025	10	16	21	40	0	12	0.1	1	31.55	93.1	6.9092	72.3716
2025	10	16	21	50	0	12	0.1	1	31.76	93.6	6.9092	72.8311
2025	10	16	22	0	0	12	0.1	1	31.66	93.6	6.9092	72.6014
2025	10	16	22	10	0	12	0.1	1	31.08	94.1	6.9092	71.2229
2025	10	16	22	20	0	12	0.1	1	31.18	94.2	6.9092	71.4527
2025	10	16	22	30	0	12	0.1	1	32.12	95	6.9092	73.5205
2025	10	16	22	40	0	12	0.1	1	31.22	92.2	6.9031	71.6166
2025	10	16	22	50	0	12	0.1	1	32.05	93.2	6.9031	73.453
2025	10	16	23	0	0	12	0.1	1	31.13	95.2	6.9031	71.1576
2025	10	16	23	10	0	12	0.1	1	30.43	92.4	6.9031	69.7804
2025	10	16	23	20	0	12	0.1	1	30.06	93.6	6.9031	68.8622
2025	10	16	23	30	0	12	0.1	1	32.08	93.9	6.9031	73.4531
2025	10	16	23	40	0	12	0.1	1	31.56	93.5	6.9031	72.3054
2025	10	16	23	50	0	12	0.1	1	31.34	92.9	6.9031	71.8463
2025	10	17	0	0	0	12	0.1	1	30.95	93.3	6.9031	70.9282

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	17	0	10	0	12	0.1	1	31.14	92.8	6.9031	71.3873
2025	10	17	0	20	0	12	0.1	1	31.86	93.4	6.9031	72.9941
2025	10	17	0	30	0	12	0.1	1	30.44	93	6.9031	69.7805
2025	10	17	0	40	0	12	0.1	1	30.14	92.9	6.9031	69.0919
2025	10	17	0	50	0	12	0.1	1	31.88	94	6.9031	72.9941
2025	10	17	1	0	0	12	0.1	1	31.55	93.3	6.9031	72.3055
2025	10	17	1	10	0	12	0.1	1	30.54	93	6.9031	70.0101
2025	10	17	1	20	0	12	0.1	1	31.49	94.4	6.897	72.0097
2025	10	17	1	30	0	12	0.1	1	31.04	93	6.897	71.0924
2025	10	17	1	40	0	12	0.1	1	31.52	91.8	6.897	72.2391
2025	10	17	1	50	0	12	0.1	1	29.91	91.5	6.897	68.5698
2025	10	17	2	0	0	12	0.1	1	31.45	93.3	6.897	72.0098
2025	10	17	2	10	0	12	0.1	1	30.55	93.2	6.897	69.9458
2025	10	17	2	20	0	12	0.1	1	31.49	94.4	6.897	72.0098
2025	10	17	2	30	0	12	0.1	1	30.67	93.7	6.897	70.1752
2025	10	17	2	40	0	12	0.1	1	31.04	93	6.897	71.0925
2025	10	17	2	50	0	12	0.1	1	30.64	93	6.897	70.1752
2025	10	17	3	0	0	12	0.1	1	30.88	94.1	6.8909	70.5689
2025	10	17	3	10	0	12	0.1	1	31.48	94	6.8909	71.9436
2025	10	17	3	20	0	12	0.1	1	30.68	94.1	6.8909	70.1107
2025	10	17	3	30	0	12	0.1	1	31.03	92.4	6.897	71.0926
2025	10	17	3	40	0	12	0.1	1	31.79	94.3	6.8909	72.631
2025	10	17	3	50	0	12	0.1	1	30.74	92.8	6.8909	70.3398
2025	10	17	4	0	0	12	0.1	1	30.73	92.4	6.8909	70.3398
2025	10	17	4	10	0	12	0.1	1	31.07	93.9	6.897	71.0926
2025	10	17	4	20	0	12	0.1	1	31.26	93.7	6.8909	71.4854
2025	10	17	4	30	0	12	0.1	1	30.06	93.6	6.8909	68.736
2025	10	17	4	40	0	12	0.1	1	32.25	93.2	6.8909	73.7766
2025	10	17	4	50	0	12	0.1	1	31.35	93.1	6.8909	71.7146
2025	10	17	5	0	0	12	0.1	1	30.94	92.8	6.8909	70.7981
2025	10	17	5	10	0	12	0.1	1	31.36	93.5	6.8909	71.7146
2025	10	17	5	20	0	12	0.1	1	31.46	93.5	6.8909	71.9437
2025	10	17	5	30	0	12	0.1	1	31.83	95.2	6.8909	72.6311
2025	10	17	5	40	0	11.8	0.1	1	31.45	93.3	6.8909	71.9437
2025	10	17	5	50	0	11.8	0.1	1	30.54	93	6.8909	69.8816
2025	10	17	6	0	0	11.8	0.1	1	31.22	92.2	6.8909	71.4855
2025	10	17	6	10	0	11.8	0.1	1	30.14	92.9	6.8909	68.9652
2025	10	17	6	20	0	11.8	0.1	1	31.11	91.7	6.8909	71.2564
2025	10	17	6	30	0	11.8	0.1	1	31.36	93.5	6.8909	71.7146
2025	10	17	6	40	0	11.8	0.1	1	30.61	91.7	6.8909	70.1108
2025	10	17	6	50	0	11.8	0.1	1	31.33	95.1	6.8909	71.4855
2025	10	17	7	0	0	11.8	0.1	1	30.54	93	6.8909	69.8817
2025	10	17	7	10	0	11.8	0.1	1	30.97	93.9	6.8909	70.7982
2025	10	17	7	20	0	11.8	0.1	1	31.36	93.5	6.8909	71.7147
2025	10	17	7	30	0	11.8	0.1	1	31.42	95.1	6.8909	71.7147
2025	10	17	7	40	0	11.8	0.1	1	30.66	93.6	6.8909	70.1109
2025	10	17	7	50	0	12	0.1	1	30.66	93.6	6.8909	70.1109
2025	10	17	8	0	0	12.4	0.1	1	31.36	93.7	6.8909	71.7147

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	17	8	10	0	12.6	0.1	1	31.43	92.6	6.8909	71.9439
2025	10	17	8	20	0	12.6	0.1	1	30.23	92.5	6.8909	69.1944
2025	10	17	8	30	0	12.8	0.1	1	30.24	93	6.8909	69.1944
2025	10	17	8	40	0	12.8	0.1	1	30.06	93.6	6.8909	68.7362
2025	10	17	8	50	0	12.8	0.1	1	31.11	91.7	6.8909	71.2565
2025	10	17	9	0	0	13	0.1	1	31.05	93.3	6.8909	71.0274
2025	10	17	9	10	0	13	0.1	1	31.81	94.7	6.8909	72.6312
2025	10	17	9	20	0	13	0.1	1	30.96	93.5	6.8909	70.7982
2025	10	17	9	30	0	13	0.1	1	31.56	95.8	6.8909	71.9438
2025	10	17	9	40	0	13	0.1	1	30.01	91.7	6.8909	68.7361
2025	10	17	9	50	0	13.2	0.1	1	30.21	91.7	6.8848	69.1306
2025	10	17	10	0	0	13.2	0.1	1	31.07	93.9	6.8909	71.0272
2025	10	17	10	10	0	13.6	0.1	1	30.51	91.7	6.8848	69.8172
2025	10	17	10	20	0	13.8	0.1	1	31.44	92.9	6.8787	71.8111
2025	10	17	10	30	0	13.8	0.1	1	29.77	93.9	6.8787	67.9232
2025	10	17	10	40	0	13.8	0.1	1	30.15	93.4	6.8787	68.8379
2025	10	17	10	50	0	13.8	0.1	1	30.38	94.2	6.8787	69.2953
2025	10	17	11	0	0	13.8	0.1	1	30.13	92.5	6.8726	68.7743
2025	10	17	11	10	0	13.8	0.1	1	30.82	95	6.8726	70.1452
2025	10	17	11	20	0	13.8	0.1	1	30.34	93	6.8726	69.2312
2025	10	17	11	30	0	13.8	0.1	1	30.61	91.3	6.8726	69.9166
2025	10	17	11	40	0	13.8	0.1	1	30.02	92.3	6.8726	68.5456
2025	10	17	11	50	0	13.8	0.1	1	30.86	93.7	6.8726	70.3735
2025	10	17	12	0	0	13.8	0.1	1	31.36	93.7	6.8726	71.5158
2025	10	17	12	10	0	13.8	0.1	1	31.69	94.3	6.8726	72.2012
2025	10	17	12	20	0	13.8	0.1	1	30.47	94	6.8726	69.4593
2025	10	17	12	30	0	13.8	0.1	1	32.16	93.4	6.8726	73.3435
2025	10	17	12	40	0	13.8	0.1	1	30.14	93	6.8726	68.7738
2025	10	17	12	50	0	13.6	0.1	1	31.45	93.3	6.8726	71.744
2025	10	17	13	0	0	13.6	0.1	1	31.63	92.4	6.8726	72.2009
2025	10	17	13	10	0	13.6	0.1	1	30.17	94	6.8726	68.7736
2025	10	17	13	20	0	13.6	0.1	1	31.81	91.4	6.8665	72.5906
2025	10	17	13	30	0	13.4	0.1	1	30.04	92.9	6.8665	68.4817
2025	10	17	13	40	0	13.4	0.1	1	30.9	90.2	6.8665	70.5361
2025	10	17	13	50	0	13.4	0.1	1	31.05	93.3	6.8665	70.7643
2025	10	17	14	0	0	13.4	0.1	1	30.15	93.2	6.8665	68.7098
2025	10	17	14	10	0	13.4	0.1	1	30.11	91.1	6.8665	68.7097
2025	10	17	14	20	0	13.4	0.1	1	30.22	91.9	6.8665	68.938
2025	10	17	14	30	0	13.4	0.1	1	31.05	93.3	6.8665	70.7641
2025	10	17	14	40	0	13.4	0.1	1	31.23	92.6	6.8665	71.2206
2025	10	17	14	50	0	13.4	0.1	1	31.12	92	6.8665	70.9923
2025	10	17	15	0	0	13.4	0.1	1	30.84	92.8	6.8665	70.3074
2025	10	17	15	10	0	13.4	0.1	1	30.92	95	6.8665	70.3074
2025	10	17	15	20	0	13.4	0.1	1	31.04	92.8	6.8665	70.7639
2025	10	17	15	30	0	13.4	0.1	1	31.34	92.7	6.8665	71.4486
2025	10	17	15	40	0	13.4	0.1	1	30.25	93.2	6.8665	68.9376
2025	10	17	15	50	0	13.4	0.1	1	30.55	93.2	6.8665	69.6224
2025	10	17	16	0	0	13.2	0.1	1	29.64	93.1	6.8665	67.5679

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	17	16	10	0	13.2	0.1	1	31.11	91.5	6.8665	70.992
2025	10	17	16	20	0	13.2	0.1	1	31.04	93	6.8665	70.7637
2025	10	17	16	30	0	13.2	0.1	1	31.05	93.1	6.8665	70.7637
2025	10	17	16	40	0	13.2	0.1	1	30.25	93.2	6.8665	68.9375
2025	10	17	16	50	0	13.2	0.1	1	29.22	92.2	6.8665	66.6548
2025	10	17	17	0	0	13.4	0.1	1	30.59	94.3	6.8665	69.6223
2025	10	17	17	10	0	13.4	0.1	1	31.24	92.9	6.8665	71.2202
2025	10	17	17	20	0	13.4	0.1	1	31.42	94.9	6.8665	71.4484
2025	10	17	17	30	0	12.6	0.1	1	31.55	93.3	6.8665	71.905
2025	10	17	17	40	0	12.2	0.1	1	30.79	94.3	6.8665	70.0788
2025	10	17	17	50	0	12.2	0.1	1	31.26	93.7	6.8665	71.2201
2025	10	17	18	0	0	12.2	0.1	1	30.75	93.4	6.8665	70.0788
2025	10	17	18	10	0	12.2	0.1	1	30.96	93.7	6.8665	70.5353
2025	10	17	18	20	0	12.2	0.1	1	30.71	94.9	6.8665	69.8506
2025	10	17	18	30	0	12.2	0.1	1	30.96	93.5	6.8665	70.5354
2025	10	17	18	40	0	12.2	0.1	1	30.77	93.7	6.8665	70.0789
2025	10	17	18	50	0	12.2	0.1	1	30.73	92.4	6.8665	70.0789
2025	10	17	19	0	0	12.2	0.1	1	30.56	93.6	6.8665	69.6224
2025	10	17	19	10	0	12.2	0.1	1	29.51	91.6	6.8665	67.3397
2025	10	17	19	20	0	12.2	0.1	1	31.36	93.5	6.8665	71.4486
2025	10	17	19	30	0	12.2	0.1	1	31.37	93.8	6.8665	71.4486
2025	10	17	19	40	0	12.2	0.1	1	29.62	91.9	6.8665	67.5681
2025	10	17	19	50	0	12.2	0.1	1	31.43	92.6	6.8604	71.6107
2025	10	17	20	0	0	12	0.1	1	30.66	93.6	6.8665	69.8508
2025	10	17	20	10	0	12	0.1	1	30.04	92.9	6.8665	68.4812
2025	10	17	20	20	0	12	0.1	1	30.52	92.3	6.8665	69.6226
2025	10	17	20	30	0	12	0.1	1	31.32	92.2	6.8665	71.4488
2025	10	17	20	40	0	12	0.1	1	31.21	91.3	6.8665	71.2206
2025	10	17	20	50	0	12	0.1	1	32.05	93.2	6.8604	72.9793
2025	10	17	21	0	0	12	0.1	1	30.09	94.4	6.8604	68.4181
2025	10	17	21	10	0	12	0.1	1	31.22	92	6.8604	71.1549
2025	10	17	21	20	0	12	0.1	1	30.96	93.5	6.8604	70.4707
2025	10	17	21	30	0	12	0.1	1	30.75	93.4	6.8604	70.0146
2025	10	17	21	40	0	12	0.1	1	30.44	93	6.8604	69.3305
2025	10	17	21	50	0	12	0.1	1	31.65	93.3	6.8604	72.0673
2025	10	17	22	0	0	12	0.1	1	30.74	92.8	6.8604	70.0148
2025	10	17	22	10	0	12	0.1	1	30.61	91.5	6.8604	69.7867
2025	10	17	22	20	0	12	0.1	1	30.52	92.3	6.8604	69.5587
2025	10	17	22	30	0	12	0.1	1	30.79	94.5	6.8604	70.0149
2025	10	17	22	40	0	12	0.1	1	29.96	93.6	6.8604	68.1904
2025	10	17	22	50	0	12	0.1	1	30.46	93.6	6.8604	69.3307
2025	10	17	23	0	0	12	0.1	1	30.65	93.2	6.8604	69.7869
2025	10	17	23	10	0	12	0.1	1	30.86	93.7	6.8604	70.243
2025	10	17	23	20	0	12	0.1	1	30.65	93.4	6.8604	69.787
2025	10	17	23	30	0	12	0.1	1	31.31	91.3	6.8604	71.3834
2025	10	17	23	40	0	12	0.1	1	30.61	94.9	6.8604	69.559
2025	10	17	23	50	0	12	0.1	1	29.75	93.5	6.8604	67.7345
2025	10	18	0	0	0	12	0.1	1	31.55	93.1	6.8543	71.7732

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	18	0	10	0	12	0.1	1	30.05	93.2	6.8543	68.3554
2025	10	18	0	20	0	12	0.1	1	30.56	93.6	6.8543	69.4947
2025	10	18	0	30	0	12	0.1	1	31.78	94.1	6.8543	72.229
2025	10	18	0	40	0	12	0.1	1	31.4	94.6	6.8543	71.3176
2025	10	18	0	50	0	12	0.1	1	31.77	93.8	6.8543	72.229
2025	10	18	1	0	0	12	0.1	1	31.94	92.9	6.8543	72.6848
2025	10	18	1	10	0	12	0.1	1	30.89	94.5	6.8543	70.1784
2025	10	18	1	20	0	12	0.1	1	30.37	94	6.8543	69.0392
2025	10	18	1	30	0	12	0.1	1	30.96	93.7	6.8543	70.4063
2025	10	18	1	40	0	12	0.1	1	30.94	92.8	6.8543	70.4064
2025	10	18	1	50	0	12	0.1	1	30.77	93.7	6.8543	69.9507
2025	10	18	2	0	0	12	0.1	1	30.33	95.3	6.8543	68.8114
2025	10	18	2	10	0	12	0.1	1	31.35	93.1	6.8543	71.3178
2025	10	18	2	20	0	12	0.1	1	30.75	93.2	6.8543	69.9508
2025	10	18	2	30	0	12	0.1	1	31.11	91.5	6.8543	70.8622
2025	10	18	2	40	0	11.8	0.1	1	30.37	93.8	6.8543	69.0394
2025	10	18	2	50	0	11.8	0.1	1	31.7	94.5	6.8543	72.0015
2025	10	18	3	0	0	11.8	0.1	1	30.97	95.9	6.8543	70.1787
2025	10	18	3	10	0	11.8	0.1	1	30.82	95	6.8543	69.9509
2025	10	18	3	20	0	11.8	0.1	1	31.14	92.9	6.8543	70.8623
2025	10	18	3	30	0	11.8	0.1	1	30.97	93.9	6.8482	70.3414
2025	10	18	3	40	0	11.8	0.1	1	30.51	91.7	6.8543	69.4952
2025	10	18	3	50	0	11.8	0.1	1	31.09	94.4	6.8543	70.6345
2025	10	18	4	0	0	11.8	0.1	1	30.97	93.9	6.8543	70.4067
2025	10	18	4	10	0	11.8	0.1	1	31.25	93.3	6.8482	71.0244
2025	10	18	4	20	0	11.8	0.1	1	30.74	92.8	6.8482	69.8863
2025	10	18	4	30	0	11.8	0.1	1	30.81	91.7	6.8482	70.1139
2025	10	18	4	40	0	11.8	0.1	1	29.82	92.3	6.8543	67.9004
2025	10	18	4	50	0	11.8	0.1	1	30.43	92.4	6.8482	69.2034
2025	10	18	5	0	0	11.8	0.1	1	30.32	92.3	6.8543	69.0397
2025	10	18	5	10	0	11.8	0.1	1	31.26	93.7	6.8482	71.0246
2025	10	18	5	20	0	11.8	0.1	1	31.22	92.2	6.8482	71.0246
2025	10	18	5	30	0	11.8	0.1	1	30.67	93.7	6.8482	69.6588
2025	10	18	5	40	0	11.8	0.1	1	30.69	94.5	6.8482	69.6588
2025	10	18	5	50	0	11.8	0.1	1	31.84	92.9	6.8482	72.3905
2025	10	18	6	0	0	11.8	0.1	1	31.04	93	6.8482	70.5694
2025	10	18	6	10	0	11.8	0.1	1	31.23	95.1	6.8482	70.7971
2025	10	18	6	20	0	11.8	0.1	1	31.02	95	6.8482	70.3418
2025	10	18	6	30	0	11.8	0.1	1	31.33	95.1	6.8482	71.0247
2025	10	18	6	40	0	11.8	0.1	1	31.27	93.9	6.8482	71.0248
2025	10	18	6	50	0	11.8	0.1	1	30.77	93.9	6.8482	69.8866
2025	10	18	7	0	0	11.8	0.1	1	30.56	93.6	6.8482	69.4313
2025	10	18	7	10	0	11.8	0.1	1	30.86	93.7	6.8482	70.1143
2025	10	18	7	20	0	11.8	0.1	1	31.14	92.9	6.8482	70.7972
2025	10	18	7	30	0	11.8	0.1	1	30.57	93.8	6.8482	69.4314
2025	10	18	7	40	0	11.8	0.1	1	30.9	90.9	6.8482	70.342
2025	10	18	7	50	0	12	0.1	1	30.77	96	6.8482	69.659
2025	10	18	8	0	0	12.2	0.1	1	31.36	93.5	6.8482	71.2526

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	18	8	10	0	12.6	0.1	1	30.68	94.1	6.8482	69.6591
2025	10	18	8	20	0	12.8	0.1	1	30.85	93.3	6.8482	70.1144
2025	10	18	8	30	0	12.8	0.1	1	31.73	92.3	6.8482	72.1632
2025	10	18	8	40	0	13	0.1	1	31.46	93.6	6.8482	71.4802
2025	10	18	8	50	0	13	0.1	1	30.31	91.5	6.8482	68.9761
2025	10	18	9	0	0	13	0.1	1	29.83	92.7	6.8482	67.8379
2025	10	18	9	10	0	13	0.1	1	31.04	93	6.8482	70.5696
2025	10	18	9	20	0	13	0.1	1	30.47	93.8	6.8543	69.2679
2025	10	18	9	30	0	13.2	0.1	1	30.5	89.6	6.8543	69.4957
2025	10	18	9	40	0	13.2	0.1	1	30.74	92.8	6.8543	69.9514
2025	10	18	9	50	0	13.4	0.1	1	30.93	92.4	6.8543	70.4071
2025	10	18	10	0	0	13.4	0.1	1	31.35	93.3	6.8543	71.3185
2025	10	18	10	10	0	13.6	0.1	1	30.58	94.1	6.8543	69.4956
2025	10	18	10	20	0	13.4	0.1	1	30.23	92.5	6.8543	68.812
2025	10	18	10	30	0	13.4	0.1	1	31.36	93.7	6.8543	71.3183
2025	10	18	10	40	0	13.4	0.1	1	30.24	93	6.8543	68.8119
2025	10	18	10	50	0	13.4	0.1	1	30.44	92.8	6.8543	69.2675
2025	10	18	11	0	0	13.4	0.1	1	31.15	93.1	6.8543	70.8625
2025	10	18	11	10	0	13.6	0.1	1	30.85	93.2	6.8543	70.1788
2025	10	18	11	20	0	13.6	0.1	1	30.57	93.8	6.8543	69.4952
2025	10	18	11	30	0	13.6	0.1	1	31.27	93.9	6.8543	71.0901
2025	10	18	11	40	0	13.6	0.1	1	30.14	93	6.8543	68.5837
2025	10	18	11	50	0	13.6	0.1	1	31.19	94.4	6.8543	70.8621
2025	10	18	12	0	0	14	0.1	1	30.5	94.7	6.8543	69.2671
2025	10	18	12	10	0	14.2	0.1	1	31.22	92.2	6.8543	71.0899
2025	10	18	12	20	0	14.2	0.1	1	30.84	93	6.8543	70.1784
2025	10	18	12	30	0	14.2	0.1	1	30.13	92.5	6.8543	68.5834
2025	10	18	12	40	0	14.2	0.1	1	30.91	94.8	6.8543	70.1783
2025	10	18	12	50	0	14.2	0.1	1	30.64	92.8	6.8604	69.7871
2025	10	18	13	0	0	14.2	0.1	1	30.17	93.8	6.8604	68.6467
2025	10	18	13	10	0	14.2	0.1	1	29.8	94.6	6.8543	67.6717
2025	10	18	13	20	0	14.2	0.1	1	30.71	94.9	6.8604	69.7869
2025	10	18	13	30	0	14.2	0.1	1	30.84	95.4	6.8604	70.0149
2025	10	18	13	40	0	14.2	0.1	1	31.64	92.7	6.8604	72.0674
2025	10	18	13	50	0	14.2	0.1	1	31.62	92.2	6.8604	72.0673
2025	10	18	14	0	0	14.2	0.1	1	31.53	95.3	6.8604	71.6111
2025	10	18	14	10	0	14.2	0.1	1	30.75	93.2	6.8604	70.0146
2025	10	18	14	20	0	13.2	0.1	1	31.61	94.7	6.8604	71.8391
2025	10	18	14	30	0	13.2	0.1	1	31.18	94	6.8604	70.9268
2025	10	18	14	40	0	13.2	0.1	1	29.88	94.2	6.8604	67.9619
2025	10	18	14	50	0	13.2	0.1	1	31.1	94.6	6.8604	70.6986
2025	10	18	15	0	0	13.2	0.1	1	31.15	93.1	6.8543	70.861
2025	10	18	15	10	0	13.2	0.1	1	30.94	93	6.8543	70.4053
2025	10	18	15	20	0	13.2	0.1	1	31.35	93.3	6.8543	71.3166
2025	10	18	15	30	0	13.2	0.1	1	32.46	93.5	6.8543	73.8229
2025	10	18	15	40	0	13.2	0.1	1	30.99	94.4	6.8543	70.4052
2025	10	18	15	50	0	13.2	0.1	1	30.5	94.7	6.8604	69.33
2025	10	18	16	0	0	13.2	0.1	1	31.35	93.1	6.8604	71.3825

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	18	16	10	0	13.2	0.1	1	31.2	94.6	6.8543	70.8608
2025	10	18	16	20	0	13.2	0.1	1	31.09	94.2	6.8543	70.6329
2025	10	18	16	30	0	13.2	0.1	1	30.54	92.8	6.8604	69.558
2025	10	18	16	40	0	13.2	0.1	1	30.55	93.4	6.8543	69.4936
2025	10	18	16	50	0	13.2	0.1	1	32.16	93.4	6.8604	73.2069
2025	10	18	17	0	0	13.2	0.1	1	30.39	94.5	6.8604	69.1018
2025	10	18	17	10	0	13.2	0.1	1	31.52	92.2	6.8604	71.8385
2025	10	18	17	20	0	13.2	0.1	1	30.95	93.3	6.8604	70.4702
2025	10	18	17	30	0	12.4	0.1	1	31.94	92.9	6.8604	72.7508
2025	10	18	17	40	0	12.2	0.1	1	29.47	94.1	6.8604	67.0493
2025	10	18	17	50	0	12.2	0.1	1	31.93	92.5	6.8604	72.7508
2025	10	18	18	0	0	12.2	0.1	1	30.65	93.2	6.8604	69.786
2025	10	18	18	10	0	12.2	0.1	1	30.37	94	6.8604	69.1018
2025	10	18	18	20	0	12.2	0.1	1	31	94.6	6.8604	70.4702
2025	10	18	18	30	0	12.2	0.1	1	30.64	93	6.8604	69.786
2025	10	18	18	40	0	12.2	0.1	1	30.53	92.6	6.8604	69.558
2025	10	18	18	50	0	12.2	0.1	1	29.95	93.4	6.8604	68.1897
2025	10	18	19	0	0	12.2	0.1	1	29.65	93.5	6.8604	67.5055
2025	10	18	19	10	0	12.2	0.1	1	31.27	93.9	6.8604	71.1545
2025	10	18	19	20	0	12.2	0.1	1	30.95	93.1	6.8604	70.4703
2025	10	18	19	30	0	12.2	0.1	1	31.24	92.8	6.8604	71.1545
2025	10	18	19	40	0	12.2	0.1	1	30.94	92.8	6.8604	70.4704
2025	10	18	19	50	0	12.2	0.1	1	31.52	92.2	6.8604	71.8388
2025	10	18	20	0	0	12	0.1	1	31.39	94.4	6.8604	71.3827
2025	10	18	20	10	0	12	0.1	1	31.09	94.2	6.8604	70.6985
2025	10	18	20	20	0	12	0.1	1	30.81	91.7	6.8604	70.2425
2025	10	18	20	30	0	12	0.1	1	32.06	93.6	6.8604	72.9792
2025	10	18	20	40	0	12	0.1	1	30.3	90.6	6.8604	69.1022
2025	10	18	20	50	0	12	0.1	1	31.05	93.3	6.8604	70.6987
2025	10	18	21	0	0	12	0.1	1	30.49	94.5	6.8604	69.3304
2025	10	18	21	10	0	12	0.1	1	30.96	93.7	6.8604	70.4707
2025	10	18	21	20	0	12	0.1	1	30.75	93.4	6.8604	70.0146
2025	10	18	21	30	0	12	0.1	1	30.61	91.7	6.8604	69.7866
2025	10	18	21	40	0	12	0.1	1	30.76	93.5	6.8604	70.0147
2025	10	18	21	50	0	12	0.1	1	29.95	93.3	6.8543	68.1271
2025	10	18	22	0	0	12	0.1	1	30.7	94.7	6.8543	69.7221
2025	10	18	22	10	0	12	0.1	1	31.17	93.9	6.8543	70.8614
2025	10	18	22	20	0	12	0.1	1	30.2	94.7	6.8543	68.5829
2025	10	18	22	30	0	12	0.1	1	30.31	91.3	6.8543	69.0387
2025	10	18	22	40	0	12	0.1	1	31.05	93.1	6.8543	70.6336
2025	10	18	22	50	0	12	0.1	1	31.84	92.7	6.8543	72.4565
2025	10	18	23	0	0	12	0.1	1	31.02	92.2	6.8543	70.6337
2025	10	18	23	10	0	12	0.1	1	30.87	93.9	6.8543	70.178
2025	10	18	23	20	0	12	0.1	1	30.75	93.2	6.8543	69.9502
2025	10	18	23	30	0	12	0.1	1	31.24	92.9	6.8543	71.0895
2025	10	18	23	40	0	12	0.1	1	30.39	94.5	6.8543	69.0389
2025	10	18	23	50	0	12	0.1	1	31.45	93.3	6.8543	71.5453
2025	10	19	0	0	0	12	0.1	1	30.96	93.7	6.8543	70.406

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	19	0	10	0	12	0.1	1	30.51	91.7	6.8543	69.4947
2025	10	19	0	20	0	12	0.1	1	30.63	92.4	6.8543	69.7225
2025	10	19	0	30	0	12	0.1	1	31.03	92.6	6.8543	70.634
2025	10	19	0	40	0	12	0.1	1	30.5	94.7	6.8543	69.2669
2025	10	19	0	50	0	12	0.1	1	30.52	92.3	6.8543	69.4948
2025	10	19	1	0	0	12	0.1	1	31.19	94.4	6.8543	70.8619
2025	10	19	1	10	0	12	0.1	1	30.31	91.5	6.8482	68.9752
2025	10	19	1	20	0	12	0.1	1	30.79	94.5	6.8543	69.9505
2025	10	19	1	30	0	12	0.1	1	30.48	94.1	6.8482	69.2029
2025	10	19	1	40	0	12	0.1	1	30.73	92.6	6.8543	69.9506
2025	10	19	1	50	0	12	0.1	1	30.64	92.8	6.8482	69.6582
2025	10	19	2	0	0	12	0.1	1	30.63	95.2	6.8482	69.4306
2025	10	19	2	10	0	12	0.1	1	31.06	93.5	6.8482	70.5688
2025	10	19	2	20	0	12	0.1	1	30.64	93	6.8482	69.6582
2025	10	19	2	30	0	12	0.1	1	31.15	93.3	6.8482	70.7965
2025	10	19	2	40	0	11.8	0.1	1	30.59	94.5	6.8482	69.4306
2025	10	19	2	50	0	11.8	0.1	1	30.04	93.1	6.8482	68.2924
2025	10	19	3	0	0	11.8	0.1	1	30.52	92.1	6.8482	69.4307
2025	10	19	3	10	0	11.8	0.1	1	31.33	95.3	6.8482	71.0242
2025	10	19	3	20	0	11.8	0.1	1	30.33	92.6	6.8482	68.9754
2025	10	19	3	30	0	11.8	0.1	1	31.23	92.4	6.8482	71.0242
2025	10	19	3	40	0	11.8	0.1	1	32.02	92.1	6.8482	72.8453
2025	10	19	3	50	0	11.8	0.1	1	29.5	90.8	6.8482	67.1543
2025	10	19	4	0	0	11.8	0.1	1	30.71	91.5	6.8482	69.886
2025	10	19	4	10	0	11.8	0.1	1	31.35	93.1	6.8482	71.2519
2025	10	19	4	20	0	11.8	0.1	1	31.23	92.4	6.8482	71.0243
2025	10	19	4	30	0	11.8	0.1	1	30.22	92.3	6.8482	68.7478
2025	10	19	4	40	0	11.8	0.1	1	30.34	93	6.8482	68.9755
2025	10	19	4	50	0	11.8	0.1	1	31.09	94.4	6.8482	70.569
2025	10	19	5	0	0	11.8	0.1	1	30.92	91.9	6.8482	70.3414
2025	10	19	5	10	0	11.8	0.1	1	31.28	94.2	6.8482	71.0243
2025	10	19	5	20	0	11.8	0.1	1	30.93	95.2	6.8482	70.1138
2025	10	19	5	30	0	11.8	0.1	1	30.77	93.9	6.8482	69.8861
2025	10	19	5	40	0	11.8	0.1	1	31.55	93.1	6.8482	71.7073
2025	10	19	5	50	0	11.8	0.1	1	31.17	93.9	6.8482	70.7967
2025	10	19	6	0	0	11.8	0.1	1	31.56	93.5	6.8482	71.7073
2025	10	19	6	10	0	11.8	0.1	1	30.96	93.7	6.8482	70.3415
2025	10	19	6	20	0	11.8	0.1	1	31.09	94.4	6.8482	70.5692
2025	10	19	6	30	0	11.8	0.1	1	31.31	94.8	6.8482	71.0245
2025	10	19	6	40	0	11.8	0.1	1	30.65	93.4	6.8482	69.6586
2025	10	19	6	50	0	11.8	0.1	1	30.84	93	6.8482	70.1139
2025	10	19	7	0	0	11.8	0.1	1	30.73	92.4	6.8421	69.8215
2025	10	19	7	10	0	11.8	0.1	1	29.92	91.9	6.8421	68.0021
2025	10	19	7	20	0	11.8	0.1	1	31.04	93	6.8482	70.5693
2025	10	19	7	30	0	11.8	0.1	1	30.96	93.7	6.8421	70.2764
2025	10	19	7	40	0	11.8	0.1	1	30.65	95.6	6.8421	69.3667
2025	10	19	7	50	0	11.8	0.1	1	30.67	93.9	6.8421	69.5942
2025	10	19	8	0	0	12.2	0.1	1	30.5	94.7	6.8421	69.1393

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	19	8	10	0	12.6	0.1	1	31.96	93.6	6.8421	72.5508
2025	10	19	8	20	0	12.8	0.1	1	30.15	93.2	6.8421	68.4571
2025	10	19	8	30	0	12.8	0.1	1	31.68	94	6.8421	71.8685
2025	10	19	8	40	0	12.8	0.1	1	31.22	92.2	6.8421	70.9588
2025	10	19	8	50	0	12.8	0.1	1	30.12	91.9	6.8421	68.4571
2025	10	19	9	0	0	13	0.1	1	31.16	93.7	6.8421	70.7314
2025	10	19	9	10	0	13	0.1	1	31.98	93.9	6.8421	72.5508
2025	10	19	9	20	0	13	0.1	1	29.87	93.8	6.8421	67.7747
2025	10	19	9	30	0	13	0.1	1	31.01	91.7	6.8421	70.5039
2025	10	19	9	40	0	13.2	0.1	1	29.02	92.4	6.8421	65.9552
2025	10	19	9	50	0	13.2	0.1	1	30.63	92.6	6.8421	69.5941
2025	10	19	10	0	0	13.2	0.1	1	31.11	91.7	6.8421	70.7312
2025	10	19	10	10	0	14.2	0.1	1	30.14	92.9	6.8421	68.4568
2025	10	19	10	20	0	14.2	0.1	1	30.69	94.3	6.8421	69.594
2025	10	19	10	30	0	14.2	0.1	1	29.51	94.9	6.8421	66.8647
2025	10	19	10	40	0	14.2	0.1	1	31.23	95.1	6.8361	70.6654
2025	10	19	10	50	0	14.2	0.1	1	30.27	93.8	6.8361	68.6204
2025	10	19	11	0	0	14.2	0.1	1	30.21	91.1	6.8361	68.6203
2025	10	19	11	10	0	14.2	0.1	1	31.45	93.3	6.8361	71.3469
2025	10	19	11	20	0	14.2	0.1	1	30.44	92.8	6.8361	69.0746
2025	10	19	11	30	0	14.2	0.1	1	30.44	92.8	6.83	69.0104
2025	10	19	11	40	0	14.2	0.1	1	29.54	92.9	6.83	66.9673
2025	10	19	11	50	0	14.2	0.1	1	30.1	94.8	6.83	68.1023
2025	10	19	12	0	0	14.2	0.1	1	31.17	93.9	6.8178	70.4681
2025	10	19	12	10	0	14.2	0.1	1	30.63	95.2	6.8056	68.9798
2025	10	19	12	20	0	14.2	0.1	1	30.58	94.1	6.8056	68.9798
2025	10	19	12	30	0	14.2	0.1	1	29.68	94.3	6.8056	66.9442
2025	10	19	12	40	0	14.2	0.1	1	29.84	92.9	6.7995	67.3336
2025	10	19	12	50	0	14.2	0.1	1	30.55	93.4	6.7995	68.9152
2025	10	19	13	0	0	14.2	0.1	1	30.67	93.9	6.7995	69.1411
2025	10	19	13	10	0	14.2	0.1	1	31.11	94.8	6.8056	70.1102
2025	10	19	13	20	0	14.2	0.1	1	31.04	92.8	6.7934	69.9794
2025	10	19	13	30	0	14.2	0.1	1	30.85	93.2	6.7995	69.5928
2025	10	19	13	40	0	14.2	0.1	1	30.72	95	6.7934	69.0763
2025	10	19	13	50	0	14.2	0.1	1	31.22	92.2	6.7873	70.3649
2025	10	19	14	0	0	14.2	0.1	1	30.17	94	6.7873	67.884
2025	10	19	14	10	0	14.2	0.1	1	29.68	94.3	6.7812	66.6939
2025	10	19	14	20	0	14.2	0.1	1	30.05	93.4	6.7812	67.5951
2025	10	19	14	30	0	14.2	0.1	1	30.42	95.1	6.7812	68.271
2025	10	19	14	40	0	14.2	0.1	1	30.18	94.2	6.7751	67.7568
2025	10	19	14	50	0	14.2	0.1	1	30.22	92.3	6.769	67.9182
2025	10	19	15	0	0	14.2	0.1	1	30.29	94.4	6.7629	67.8544
2025	10	19	15	10	0	14.2	0.1	1	30.17	94	6.769	67.6932
2025	10	19	15	20	0	14.2	0.1	1	30.2	94.6	6.7507	67.5026
2025	10	19	15	30	0	14.2	0.1	1	30.2	94.6	6.7507	67.5026
2025	10	19	15	40	0	14.2	0.1	1	29.61	94.8	6.7507	66.157
2025	10	19	15	50	0	14.2	0.1	1	31.06	93.7	6.7507	69.5209
2025	10	19	16	0	0	14.2	0.1	1	29.42	95.1	6.7446	65.6466

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	19	16	10	0	14.2	0.1	1	30.63	92.6	6.7385	68.4947
2025	10	19	16	20	0	12.6	0.1	1	30.33	95.3	6.7385	67.5993
2025	10	19	16	30	0	12.2	0.1	1	30.68	94.1	6.7385	68.4947
2025	10	19	16	40	0	12.2	0.1	1	30.68	94.1	6.7385	68.4946
2025	10	19	16	50	0	12	0.1	1	30.68	94.1	6.7324	68.4301
2025	10	19	17	0	0	12	0.1	1	29.22	92.4	6.7324	65.2993
2025	10	19	17	10	0	13.4	0.1	1	30.47	94	6.7324	67.9828
2025	10	19	17	20	0	13	0.1	1	30.27	93.8	6.7324	67.5355
2025	10	19	17	30	0	11.6	0.1	1	29.52	92.1	6.7263	65.9079
2025	10	19	17	40	0	11.4	0.1	1	29.76	93.7	6.7263	66.3547
2025	10	19	17	50	0	11.4	0.1	1	30.31	91.5	6.7202	67.6313
2025	10	19	18	0	0	11.4	0.1	1	29.92	95.2	6.7202	66.5153
2025	10	19	18	10	0	11.2	0.1	1	29.84	93.1	6.7202	66.5153
2025	10	19	18	20	0	12.2	0.1	1	30.01	91.7	6.7141	66.8984
2025	10	19	18	30	0	12.2	0.1	1	29.23	92.7	6.708	65.0529
2025	10	19	18	40	0	12.2	0.1	1	28.84	93	6.7019	64.101
2025	10	19	18	50	0	12.2	0.1	1	29.93	92.5	6.6958	66.4863
2025	10	19	19	0	0	12	0.1	1	29.94	92.9	6.6898	66.4232
2025	10	19	19	10	0	12	0.1	1	29.54	93.1	6.6837	65.4725
2025	10	19	19	20	0	11.6	0.1	1	29.53	95.4	6.6837	65.2505
2025	10	19	19	30	0	11.4	0.1	1	29.71	96.8	6.6776	65.4103
2025	10	19	19	40	0	11.4	0.1	1	30.01	95	6.6776	66.2972
2025	10	19	19	50	0	11.4	0.1	1	28.9	90.8	6.6776	64.08
2025	10	19	20	0	0	11.4	0.1	1	28.92	92.4	6.6715	64.019
2025	10	19	20	10	0	11.4	0.1	1	28.87	94	6.6715	63.7976
2025	10	19	20	20	0	12	0.1	1	29.18	94.1	6.6715	64.4621
2025	10	19	20	30	0	12	0.1	1	29.35	93.3	6.6654	64.8434
2025	10	19	20	40	0	12	0.1	1	29.03	92.8	6.6654	64.1795
2025	10	19	20	50	0	12	0.1	1	29.5	90.2	6.6654	65.2861
2025	10	19	21	0	0	12	0.1	1	29.58	94.3	6.6593	65.2239
2025	10	19	21	10	0	12	0.1	1	27.95	93.5	6.6593	61.6864
2025	10	19	21	20	0	12	0.1	1	29.31	94.9	6.6593	64.5607
2025	10	19	21	30	0	12	0.1	1	29.14	93	6.6593	64.3396
2025	10	19	21	40	0	12	0.1	1	28.85	93.4	6.6532	63.6156
2025	10	19	21	50	0	12	0.1	1	28.41	91.6	6.6532	62.7321
2025	10	19	22	0	0	12	0.1	1	29.53	92.5	6.6532	65.1619
2025	10	19	22	10	0	12	0.1	1	30.21	91.3	6.6532	66.7081
2025	10	19	22	20	0	12	0.1	1	28.54	93.2	6.6471	62.893
2025	10	19	22	30	0	12	0.1	1	30.36	93.6	6.6471	66.8652
2025	10	19	22	40	0	12	0.1	1	29.65	93.3	6.6471	65.3205
2025	10	19	22	50	0	12	0.1	1	28.76	93.6	6.641	63.2739
2025	10	19	23	0	0	12	0.1	1	29.16	93.7	6.641	64.1558
2025	10	19	23	10	0	12	0.1	1	28.58	94.2	6.641	62.833
2025	10	19	23	20	0	12	0.1	1	28.32	92.2	6.6349	62.3324
2025	10	19	23	30	0	12	0.1	1	27.84	92.9	6.6349	61.2312
2025	10	19	23	40	0	12	0.1	1	28.62	92.2	6.6349	62.9933
2025	10	19	23	50	0	12	0.1	1	28.03	92.9	6.6288	61.6127
2025	10	20	0	0	0	12	0.1	1	28.64	93	6.6288	62.933

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	20	0	10	0	12	0.1	1	29.08	94.1	6.6227	63.7521
2025	10	20	0	20	0	12	0.1	1	28.54	93.2	6.6227	62.653
2025	10	20	0	30	0	12	0.1	1	29.44	93.1	6.6166	64.5695
2025	10	20	0	40	0	12	0.1	1	29.44	92.9	6.6166	64.5695
2025	10	20	0	50	0	12	0.1	1	28.66	93.8	6.6105	62.7523
2025	10	20	1	0	0	12	0.1	1	29.16	93.7	6.6044	63.788
2025	10	20	1	10	0	12	0.1	1	28.9	94.8	6.5983	63.0697
2025	10	20	1	20	0	12	0.1	1	28.12	92	6.5983	61.5368
2025	10	20	1	30	0	12	0.1	1	28.83	92.8	6.5922	63.009
2025	10	20	1	40	0	12	0.1	1	29.94	93.1	6.5922	65.4156
2025	10	20	1	50	0	12	0.1	1	28.92	92.4	6.5922	63.2279
2025	10	20	2	0	0	11.8	0.1	1	28.42	92	6.5861	62.0741
2025	10	20	2	10	0	11.8	0.1	1	28.58	94.2	6.5861	62.2927
2025	10	20	2	20	0	11.8	0.1	1	29.59	94.5	6.5861	64.4784
2025	10	20	2	30	0	11.8	0.1	1	28.4	94.8	6.5861	61.8556
2025	10	20	2	40	0	11.8	0.1	1	28.05	93.5	6.58	61.1409
2025	10	20	2	50	0	11.8	0.1	1	29.22	92	6.58	63.7612
2025	10	20	3	0	0	11.8	0.1	1	28.53	92.4	6.58	62.2327
2025	10	20	3	10	0	11.8	0.1	1	28.63	92.8	6.58	62.4511
2025	10	20	3	20	0	11.8	0.1	1	27.67	93.9	6.58	60.2675
2025	10	20	3	30	0	11.8	0.1	1	29.22	92.4	6.58	63.7613
2025	10	20	3	40	0	11.8	0.1	1	29.24	95.7	6.58	63.5429
2025	10	20	3	50	0	11.8	0.1	1	28.82	92.4	6.5739	62.8272
2025	10	20	4	0	0	11.8	0.1	1	27.3	94.8	6.5739	59.3368
2025	10	20	4	10	0	11.8	0.1	1	28.35	93.4	6.5739	61.7364
2025	10	20	4	20	0	11.8	0.1	1	28.78	94.4	6.5739	62.609
2025	10	20	4	30	0	11.8	0.1	1	29.12	95.1	6.5739	63.2635
2025	10	20	4	40	0	11.8	0.1	1	29.18	94.1	6.5739	63.4817
2025	10	20	4	50	0	11.8	0.1	1	28.29	94.7	6.5739	61.5183
2025	10	20	5	0	0	11.8	0.1	1	28.73	92.8	6.5678	62.5486
2025	10	20	5	10	0	11.8	0.1	1	27.55	93.5	6.5678	59.9333
2025	10	20	5	20	0	11.8	0.1	1	28.73	92.4	6.5678	62.5486
2025	10	20	5	30	0	11.8	0.1	1	29.08	94.1	6.5678	63.2025
2025	10	20	5	40	0	11.8	0.1	1	28.68	94.4	6.5678	62.3307
2025	10	20	5	50	0	11.8	0.1	1	28.78	94.2	6.5678	62.5487
2025	10	20	6	0	0	11.8	0.1	1	28.61	91.2	6.5678	62.3307
2025	10	20	6	10	0	11.8	0.1	1	29.46	93.7	6.5678	64.0743
2025	10	20	6	20	0	11.8	0.1	1	27.15	93.4	6.5678	59.0617
2025	10	20	6	30	0	11.8	0.1	1	28.84	93	6.5678	62.7667
2025	10	20	6	40	0	11.8	0.1	1	27.55	93.5	6.5617	59.8755
2025	10	20	6	50	0	11.8	0.1	1	29.99	94.4	6.5617	65.101
2025	10	20	7	0	0	11.8	0.1	1	28.77	94	6.5617	62.4882
2025	10	20	7	10	0	11.8	0.1	1	28.91	95	6.5617	62.706
2025	10	20	7	20	0	11.8	0.1	1	27.77	93.9	6.5617	60.311
2025	10	20	7	30	0	11.8	0.1	1	28.45	93.4	6.5617	61.8351
2025	10	20	7	40	0	11.8	0.1	1	28.87	94	6.5617	62.706
2025	10	20	7	50	0	11.8	0.1	1	28.76	93.8	6.5617	62.4883
2025	10	20	8	0	0	12.2	0.1	1	28.5	94.8	6.5617	61.8351

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	20	8	10	0	12.4	0.1	1	29.26	93.7	6.5617	63.577
2025	10	20	8	20	0	12.8	0.1	1	28.31	91.4	6.5617	61.6174
2025	10	20	8	30	0	12.8	0.1	1	27.55	93.5	6.5556	59.8176
2025	10	20	8	40	0	13	0.1	1	29.55	93.5	6.5556	64.168
2025	10	20	8	50	0	12.8	0.1	1	28.01	91.6	6.5556	60.9052
2025	10	20	9	0	0	13	0.1	1	28.15	93.3	6.5556	61.1227
2025	10	20	9	10	0	13	0.1	1	28.33	92.6	6.5556	61.5577
2025	10	20	9	20	0	13.2	0.1	1	28.64	93.2	6.5556	62.2103
2025	10	20	9	30	0	13.4	0.1	1	27.23	92.5	6.5556	59.165
2025	10	20	9	40	0	13.6	0.1	1	27.64	92.9	6.5556	60.035
2025	10	20	9	50	0	13.2	0.1	1	27.75	93.5	6.5556	60.2525
2025	10	20	10	0	0	13.2	0.1	1	28.36	93.8	6.5556	61.5576
2025	10	20	10	10	0	13.4	0.1	1	28.23	92.6	6.5495	61.2806
2025	10	20	10	20	0	13.4	0.1	1	28.37	94	6.5495	61.4979
2025	10	20	10	30	0	14.2	0.1	1	28.23	92.6	6.5495	61.2805
2025	10	20	10	40	0	14.2	0.1	1	27.43	92.7	6.5495	59.542
2025	10	20	10	50	0	14.2	0.1	1	28.34	95.7	6.5495	61.2804
2025	10	20	11	0	0	14.2	0.1	1	27.65	93.5	6.5495	59.9765
2025	10	20	11	10	0	14.2	0.1	1	28.35	95.9	6.5434	61.2208
2025	10	20	11	20	0	14.2	0.1	1	28.45	93.4	6.5434	61.6549
2025	10	20	11	30	0	14.2	0.1	1	28.35	93.4	6.5374	61.3781
2025	10	20	11	40	0	14.2	0.1	1	28.15	93.5	6.5313	60.8851
2025	10	20	11	50	0	14.2	0.1	1	27.55	93.5	6.5313	59.585
2025	10	20	12	0	0	14.2	0.1	1	27.72	92.3	6.5252	59.9599
2025	10	20	12	10	0	14.2	0.1	1	27.79	94.5	6.5252	59.9598
2025	10	20	12	20	0	14.2	0.1	1	27.64	93.1	6.5252	59.7433
2025	10	20	12	30	0	14.2	0.1	1	28.26	93.7	6.5252	61.042
2025	10	20	12	40	0	14.2	0.1	1	27.55	93.3	6.5252	59.5267
2025	10	20	12	50	0	14.2	0.1	1	28.42	92	6.5252	61.4748
2025	10	20	13	0	0	14.2	0.1	1	28.48	94.2	6.5252	61.4747
2025	10	20	13	10	0	14.2	0.1	1	28.05	93.5	6.5252	60.6088
2025	10	20	13	20	0	14.2	0.1	1	28.49	94.6	6.5252	61.4746
2025	10	20	13	30	0	14.2	0.1	1	27.92	92.3	6.5252	60.3923
2025	10	20	13	40	0	14.2	0.1	1	27.92	92.3	6.5252	60.3922
2025	10	20	13	50	0	14.2	0.1	1	27.74	92.9	6.5252	59.9592
2025	10	20	14	0	0	14.2	0.1	1	29.45	95.8	6.5252	63.4225
2025	10	20	14	10	0	14.2	0.1	1	27.95	93.3	6.5252	60.3921
2025	10	20	14	20	0	14.2	0.1	1	28.04	93.1	6.5252	60.6085
2025	10	20	14	30	0	14.2	0.1	1	27.83	92.7	6.5252	60.1755
2025	10	20	14	40	0	14.2	0.1	1	26.91	91.7	6.5252	58.2273
2025	10	20	14	50	0	14.2	0.1	1	28.19	94.5	6.5252	60.8248
2025	10	20	15	0	0	14.2	0.1	1	28.43	92.4	6.5252	61.4741
2025	10	20	15	10	0	14.2	0.1	1	28.31	95.1	6.5252	61.0412
2025	10	20	15	20	0	14.2	0.1	1	28.36	93.6	6.5252	61.2576
2025	10	20	15	30	0	14.2	0.1	1	27.76	93.7	6.5191	59.9004
2025	10	20	15	40	0	14.2	0.1	1	28.12	92.2	6.5191	60.7654
2025	10	20	15	50	0	14	0.1	1	27.85	93.3	6.5191	60.1166
2025	10	20	16	0	0	14	0.1	1	29.33	92.5	6.5191	63.3603

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	20	16	10	0	14	0.1	1	28.62	95.2	6.5191	61.6303
2025	10	20	16	20	0	13.2	0.1	1	29.46	96	6.5191	63.3602
2025	10	20	16	30	0	13.2	0.1	1	28.91	95	6.5191	62.279
2025	10	20	16	40	0	13.2	0.1	1	28.46	96.1	6.5191	61.1977
2025	10	20	16	50	0	13.2	0.1	1	28.92	95.2	6.5191	62.2789
2025	10	20	17	0	0	13.2	0.1	1	27.5	94.8	6.513	59.1937
2025	10	20	17	10	0	13.2	0.1	1	29.02	92	6.513	62.6503
2025	10	20	17	20	0	13	0.1	1	27.8	94.7	6.513	59.8418
2025	10	20	17	30	0	12.4	0.1	1	27.32	92.3	6.513	58.9776
2025	10	20	17	40	0	12.2	0.1	1	27.65	93.3	6.513	59.6257
2025	10	20	17	50	0	12.2	0.1	1	28.85	93.4	6.513	62.2182
2025	10	20	18	0	0	12.2	0.1	1	28.36	93.8	6.513	61.138
2025	10	20	18	10	0	12	0.1	1	28.57	94	6.513	61.57
2025	10	20	18	20	0	12.2	0.1	1	27.93	92.7	6.5069	60.215
2025	10	20	18	30	0	12.2	0.1	1	29	94.7	6.513	62.4342
2025	10	20	18	40	0	12.2	0.1	1	27.91	91.6	6.513	60.2739
2025	10	20	18	50	0	12.2	0.1	1	28.2	94.9	6.5069	60.6467
2025	10	20	19	0	0	12.2	0.1	1	27.69	94.6	6.5069	59.5676
2025	10	20	19	10	0	12.2	0.1	1	27.17	94	6.5069	58.4885
2025	10	20	19	20	0	12	0.1	1	28.1	90.2	6.5069	60.6468
2025	10	20	19	30	0	12	0.1	1	27.53	92.7	6.5069	59.3519
2025	10	20	19	40	0	12	0.1	1	28.53	92.4	6.5069	61.5101
2025	10	20	19	50	0	12	0.1	1	27.47	94.2	6.5069	59.1361
2025	10	20	20	0	0	12	0.1	1	28.42	92.2	6.5069	61.2943
2025	10	20	20	10	0	12	0.1	1	28.25	93.4	6.5008	60.8033
2025	10	20	20	20	0	12	0.1	1	28.23	92.6	6.5008	60.8033
2025	10	20	20	30	0	12	0.1	1	27.73	92.5	6.5008	59.7253
2025	10	20	20	40	0	12	0.1	1	29.12	92	6.5008	62.7439
2025	10	20	20	50	0	12	0.1	1	27.74	93.1	6.5008	59.7253
2025	10	20	21	0	0	12	0.1	1	26.98	94.5	6.5008	58.0005
2025	10	20	21	10	0	12	0.1	1	28.69	94.6	6.5008	61.6659
2025	10	20	21	20	0	12	0.1	1	26.65	93.4	6.4947	57.2976
2025	10	20	21	30	0	12	0.1	1	28.85	93.4	6.4947	62.0365
2025	10	20	21	40	0	12	0.1	1	27.03	92.8	6.4947	58.1593
2025	10	20	21	50	0	12	0.1	1	28.46	93.8	6.4947	61.175
2025	10	20	22	0	0	12	0.1	1	27.27	94.2	6.4947	58.5901
2025	10	20	22	10	0	12	0.1	1	27.69	94.6	6.4947	59.4518
2025	10	20	22	20	0	12	0.1	1	27.64	93.1	6.4947	59.4518
2025	10	20	22	30	0	12	0.1	1	27.95	93.5	6.4947	60.0981
2025	10	20	22	40	0	12	0.1	1	28.11	95.1	6.4947	60.3135
2025	10	20	22	50	0	12	0.1	1	27.51	91.9	6.4947	59.2365
2025	10	20	23	0	0	12	0.1	1	26.85	93.6	6.4886	57.6722
2025	10	20	23	10	0	12	0.1	1	27.83	92.7	6.4886	59.8242
2025	10	20	23	20	0	12	0.1	1	27.66	93.7	6.4886	59.3938
2025	10	20	23	30	0	12	0.1	1	27.55	93.5	6.4886	59.1787
2025	10	20	23	40	0	12	0.1	1	27.83	95.6	6.4886	59.6091
2025	10	20	23	50	0	12	0.1	1	27.79	94.5	6.4886	59.6091
2025	10	21	0	0	0	12	0.1	1	27.93	92.7	6.4886	60.0395

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	21	0	10	0	12	0.1	1	28.76	93.6	6.4886	61.7611
2025	10	21	0	20	0	12	0.1	1	27.44	92.9	6.4886	58.9636
2025	10	21	0	30	0	12	0.1	1	28.35	93.4	6.4886	60.9004
2025	10	21	0	40	0	12	0.1	1	27.75	93.5	6.4886	59.6093
2025	10	21	0	50	0	12	0.1	1	27.36	93.8	6.4886	58.7485
2025	10	21	1	0	0	12	0.1	1	27.16	93.8	6.4825	58.261
2025	10	21	1	10	0	12	0.1	1	27.08	94.4	6.4825	58.0461
2025	10	21	1	20	0	12	0.1	1	27.2	94.9	6.4825	58.2611
2025	10	21	1	30	0	12	0.1	1	27.31	91.5	6.4825	58.6911
2025	10	21	1	40	0	12	0.1	1	27.54	92.9	6.4825	59.1211
2025	10	21	1	50	0	12	0.1	1	28.25	93.4	6.4825	60.626
2025	10	21	2	0	0	12	0.1	1	27.74	92.9	6.4825	59.5511
2025	10	21	2	10	0	12	0.1	1	27.58	94.4	6.4825	59.1212
2025	10	21	2	20	0	11.8	0.1	1	26.62	91.9	6.4825	57.1863
2025	10	21	2	30	0	11.8	0.1	1	27.71	95.2	6.4764	59.278
2025	10	21	2	40	0	11.8	0.1	1	27	90.8	6.4825	58.0463
2025	10	21	2	50	0	11.8	0.1	1	28.43	92.4	6.4825	61.0561
2025	10	21	3	0	0	11.8	0.1	1	27.04	93	6.4764	57.9894
2025	10	21	3	10	0	11.8	0.1	1	27.33	92.5	6.4764	58.6338
2025	10	21	3	20	0	11.8	0.1	1	28.34	95.7	6.4764	60.5668
2025	10	21	3	30	0	11.8	0.1	1	27.32	95.5	6.4764	58.419
2025	10	21	3	40	0	11.8	0.1	1	27.14	93.2	6.4764	58.2043
2025	10	21	3	50	0	11.8	0.1	1	27.48	94.4	6.4764	58.8486
2025	10	21	4	0	0	11.8	0.1	1	27.53	92.7	6.4764	59.0634
2025	10	21	4	10	0	11.8	0.1	1	28.63	92.8	6.4703	61.3657
2025	10	21	4	20	0	11.8	0.1	1	27.35	96.1	6.4764	58.4191
2025	10	21	4	30	0	11.8	0.1	1	27.68	94.4	6.4764	59.2782
2025	10	21	4	40	0	11.8	0.1	1	27.33	92.7	6.4764	58.6339
2025	10	21	4	50	0	11.8	0.1	1	28.66	93.8	6.4703	61.3657
2025	10	21	5	0	0	11.8	0.1	1	27.93	92.7	6.4764	59.9226
2025	10	21	5	10	0	11.8	0.1	1	27.62	92.1	6.4764	59.2783
2025	10	21	5	20	0	11.8	0.1	1	26.41	95.2	6.4703	56.4308
2025	10	21	5	30	0	11.8	0.1	1	27.21	91.9	6.4703	58.3619
2025	10	21	5	40	0	11.8	0.1	1	27.57	94	6.4703	59.0056
2025	10	21	5	50	0	11.8	0.1	1	28.08	94.3	6.4703	60.0784
2025	10	21	6	0	0	11.8	0.1	1	26.41	95.2	6.4703	56.4308
2025	10	21	6	10	0	11.8	0.1	1	27.8	94.7	6.4703	59.4347
2025	10	21	6	20	0	11.8	0.1	1	27.11	91.7	6.4703	58.1474
2025	10	21	6	30	0	11.8	0.1	1	27.39	94.6	6.4703	58.5765
2025	10	21	6	40	0	11.8	0.1	1	27.5	94.8	6.4703	58.7911
2025	10	21	6	50	0	11.8	0.1	1	28.06	93.9	6.4703	60.0785
2025	10	21	7	0	0	11.8	0.1	1	27.09	94.7	6.4703	57.9328
2025	10	21	7	10	0	11.8	0.1	1	26.57	96.5	6.4703	56.6455
2025	10	21	7	20	0	11.8	0.1	1	27.5	94.8	6.4703	58.7911
2025	10	21	7	30	0	11.8	0.1	1	28.47	94	6.4703	60.9368
2025	10	21	7	40	0	11.8	0.1	1	28.88	94.4	6.4703	61.7951
2025	10	21	7	50	0	11.8	0.1	1	26.68	94.5	6.4703	57.0746
2025	10	21	8	0	0	12.2	0.1	1	28.07	94.1	6.4703	60.0786

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	21	8	10	0	12.4	0.1	1	27.05	93.4	6.4703	57.9329
2025	10	21	8	20	0	12.8	0.1	1	27.95	93.5	6.4703	59.864
2025	10	21	8	30	0	12.8	0.1	1	27.57	94	6.4703	59.0058
2025	10	21	8	40	0	13	0.1	1	27.73	92.7	6.4703	59.4349
2025	10	21	8	50	0	13	0.1	1	28.35	93.4	6.4642	60.6626
2025	10	21	9	0	0	13.2	0.1	1	27.45	93.6	6.4642	58.7334
2025	10	21	9	10	0	13.4	0.1	1	27.86	93.9	6.4642	59.5908
2025	10	21	9	20	0	13.4	0.1	1	28.88	94.4	6.4642	61.7344
2025	10	21	9	30	0	13.6	0.1	1	27.73	92.7	6.4581	59.3181
2025	10	21	9	40	0	14.2	0.1	1	28.05	93.5	6.4642	60.0195
2025	10	21	9	50	0	14.2	0.1	1	26.82	95.3	6.4581	57.1765
2025	10	21	10	0	0	14.2	0.1	1	28.77	94	6.4581	61.4594
2025	10	21	10	10	0	14.2	0.1	1	27.55	93.5	6.4581	58.8896
2025	10	21	10	20	0	14.2	0.1	1	27.24	92.9	6.4581	58.2471
2025	10	21	10	30	0	14.2	0.1	1	28.16	93.9	6.452	60.1152
2025	10	21	10	40	0	14.2	0.1	1	28.54	93.2	6.4581	61.0309
2025	10	21	10	50	0	14.2	0.1	1	27.85	93.5	6.4581	59.5319
2025	10	21	11	0	0	14.2	0.1	1	27.12	95.5	6.4581	57.8187
2025	10	21	11	10	0	14.2	0.1	1	26.38	94.3	6.4581	56.3196
2025	10	21	11	20	0	14.2	0.1	1	27.36	93.8	6.4581	58.461
2025	10	21	11	30	0	14.2	0.1	1	27.5	94.8	6.4581	58.6751
2025	10	21	11	40	0	14.2	0.1	1	26.79	94.7	6.4581	57.176
2025	10	21	11	50	0	14.2	0.1	1	26.52	91.9	6.4581	56.7477
2025	10	21	12	0	0	14.2	0.1	1	27.77	93.9	6.4581	59.3173
2025	10	21	12	10	0	14.2	0.1	1	28.75	93.4	6.4581	61.4587
2025	10	21	12	20	0	14.2	0.1	1	27.61	95.2	6.4581	58.8889
2025	10	21	12	30	0	14.2	0.1	1	28.88	94.2	6.4581	61.6727
2025	10	21	12	40	0	14.2	0.1	1	28.3	94.9	6.4581	60.3878
2025	10	21	12	50	0	14.2	0.1	1	26.59	94.7	6.4581	56.7473
2025	10	21	13	0	0	14.2	0.1	1	27.61	95.2	6.4581	58.8887
2025	10	21	13	10	0	14.2	0.1	1	27.86	93.7	6.4581	59.531
2025	10	21	13	20	0	14.2	0.1	1	27.33	92.5	6.4581	58.4603
2025	10	21	13	30	0	14.2	0.1	1	28.46	93.8	6.4581	60.8158
2025	10	21	13	40	0	14.2	0.1	1	27.84	93.1	6.4581	59.5309
2025	10	21	13	50	0	14.2	0.1	1	27.64	92.9	6.4581	59.1025
2025	10	21	14	0	0	14.2	0.1	1	28.46	93.8	6.4581	60.8156
2025	10	21	14	10	0	14.2	0.1	1	28.06	93.7	6.4581	59.959
2025	10	21	14	20	0	14.2	0.1	1	27.75	93.5	6.4581	59.3165
2025	10	21	14	30	0	14.2	0.1	1	27.73	92.5	6.4581	59.3165
2025	10	21	14	40	0	14.2	0.1	1	27.83	92.7	6.4581	59.5306
2025	10	21	14	50	0	14.2	0.1	1	27.91	91.8	6.4581	59.7446
2025	10	21	15	0	0	14.2	0.1	1	27.04	93.2	6.4581	57.8174
2025	10	21	15	10	0	14.2	0.1	1	28.01	91.8	6.4581	59.9587
2025	10	21	15	20	0	14.2	0.1	1	27.92	92.3	6.4581	59.7445
2025	10	21	15	30	0	14.2	0.1	1	27.49	94.6	6.4581	58.6738
2025	10	21	15	40	0	14.2	0.1	1	27.17	94	6.4581	58.0314
2025	10	21	15	50	0	14.2	0.1	1	27.26	93.8	6.4581	58.2455
2025	10	21	16	0	0	14.2	0.1	1	27.75	93.5	6.4581	59.3161

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	21	16	10	0	14	0.1	1	27.98	94.3	6.4581	59.7444
2025	10	21	16	20	0	13.2	0.1	1	26.95	93.6	6.4581	57.603
2025	10	21	16	30	0	13.2	0.1	1	28.03	92.9	6.4581	59.9585
2025	10	21	16	40	0	13.2	0.1	1	27.46	93.8	6.452	58.6159
2025	10	21	16	50	0	13.2	0.1	1	28.03	92.9	6.452	59.8994
2025	10	21	17	0	0	13.2	0.1	1	27.57	94	6.452	58.8298
2025	10	21	17	10	0	12.6	0.1	1	27.76	93.7	6.452	59.2576
2025	10	21	17	20	0	13	0.1	1	26.94	93.2	6.4581	57.6029
2025	10	21	17	30	0	12.2	0.1	1	27.24	93.2	6.4581	58.2453
2025	10	21	17	40	0	12.2	0.1	1	27.12	95.5	6.4581	57.817
2025	10	21	17	50	0	12.2	0.1	1	26.48	94.3	6.452	56.4766
2025	10	21	18	0	0	12.2	0.1	1	27.08	94.4	6.452	57.7601
2025	10	21	18	10	0	12.2	0.1	1	27.62	92.1	6.4581	59.1019
2025	10	21	18	20	0	12.2	0.1	1	28.38	94.2	6.452	60.5412
2025	10	21	18	30	0	12.2	0.1	1	28.39	94.4	6.452	60.5412
2025	10	21	18	40	0	12.2	0.1	1	28.23	92.6	6.452	60.3273
2025	10	21	18	50	0	12	0.1	1	27.55	93.3	6.452	58.8298
2025	10	21	19	0	0	12	0.1	1	27.56	93.7	6.452	58.8299
2025	10	21	19	10	0	12	0.1	1	27.15	93.4	6.452	57.9742
2025	10	21	19	20	0	12	0.1	1	27.33	92.7	6.452	58.402
2025	10	21	19	30	0	12	0.1	1	27.95	93.5	6.452	59.6856
2025	10	21	19	40	0	12	0.1	1	27.04	93.2	6.452	57.7603
2025	10	21	19	50	0	12	0.1	1	26.75	93.6	6.452	57.1185
2025	10	21	20	0	0	12	0.1	1	26.76	93.9	6.452	57.1186
2025	10	21	20	10	0	12	0.1	1	27.55	93.5	6.452	58.83
2025	10	21	20	20	0	12	0.1	1	25.83	92.9	6.452	55.1933
2025	10	21	20	30	0	12	0.1	1	27.48	94.4	6.4459	58.5584
2025	10	21	20	40	0	12	0.1	1	26.64	93.2	6.452	56.9048
2025	10	21	20	50	0	11.8	0.1	1	27.63	92.7	6.4459	58.9859
2025	10	21	21	0	0	11.6	0.1	1	27.45	93.6	6.4459	58.5585
2025	10	21	21	10	0	12	0.1	1	26.74	93.2	6.4459	57.0625
2025	10	21	21	20	0	12	0.1	1	27.23	92.5	6.4459	58.1311
2025	10	21	21	30	0	12	0.1	1	26.96	93.8	6.4459	57.49
2025	10	21	21	40	0	12	0.1	1	26.85	93.4	6.4459	57.2763
2025	10	21	21	50	0	12	0.1	1	27.99	94.5	6.4459	59.6272
2025	10	21	22	0	0	12	0.1	1	27.32	92.3	6.4459	58.3449
2025	10	21	22	10	0	12	0.1	1	26.95	93.6	6.4459	57.4901
2025	10	21	22	20	0	12	0.1	1	26.82	91.9	6.4459	57.2764
2025	10	21	22	30	0	12	0.1	1	27.82	92.1	6.4459	59.4136
2025	10	21	22	40	0	12	0.1	1	26.73	95.6	6.4459	56.849
2025	10	21	22	50	0	12	0.1	1	26.39	94.8	6.4459	56.2079
2025	10	21	23	0	0	12	0.1	1	28.18	94.3	6.4398	59.9956
2025	10	21	23	10	0	12	0.1	1	27.25	93.6	6.4398	58.0741
2025	10	21	23	20	0	12	0.1	1	28.94	93.2	6.4398	61.7037
2025	10	21	23	30	0	12	0.1	1	26.45	93.7	6.4398	56.366
2025	10	21	23	40	0	12	0.1	1	27.25	93.4	6.4398	58.0741
2025	10	21	23	50	0	12	0.1	1	27.34	93.1	6.4398	58.2876
2025	10	22	0	0	0	12	0.1	1	26.73	92.8	6.4398	57.0066

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	22	0	10	0	11.6	0.1	1	26.84	93.2	6.4398	57.2202
2025	10	22	0	20	0	12	0.1	1	27.17	94	6.4398	57.8607
2025	10	22	0	30	0	12	0.1	1	27.15	93.6	6.4398	57.8607
2025	10	22	0	40	0	12	0.1	1	27.24	93.2	6.4398	58.0742
2025	10	22	0	50	0	12	0.1	1	28.94	95.6	6.4398	61.4904
2025	10	22	1	0	0	12	0.1	1	26.12	92	6.4398	55.7257
2025	10	22	1	10	0	12	0.1	1	28.06	93.7	6.4398	59.7824
2025	10	22	1	20	0	12	0.1	1	27.11	91.9	6.4398	57.8608
2025	10	22	1	30	0	12	0.1	1	27.65	93.5	6.4398	58.9284
2025	10	22	1	40	0	12	0.1	1	27.91	91.2	6.4398	59.5689
2025	10	22	1	50	0	12	0.1	0.9	27.45	93.3	6.4337	58.4436
2025	10	22	2	0	0	12	0.1	1	26.95	96	6.4398	57.2203
2025	10	22	2	10	0	12	0.1	0.9	26.74	93	6.4337	56.9506
2025	10	22	2	20	0	12	0.1	0.9	27.17	94	6.4337	57.8038
2025	10	22	2	30	0	12	0.1	1	28.23	92.8	6.4398	60.2095
2025	10	22	2	40	0	12	0.1	0.9	26.65	93.4	6.4337	56.7373
2025	10	22	2	50	0	12	0.1	0.9	28.21	91.2	6.4337	60.1501
2025	10	22	3	0	0	12	0.1	0.9	26.15	93.5	6.4337	55.6708
2025	10	22	3	10	0	11.8	0.1	0.9	27.05	93.6	6.4337	57.5905
2025	10	22	3	20	0	11.8	0.1	0.9	28.55	93.4	6.4337	60.79
2025	10	22	3	30	0	11.8	0.1	0.9	27.98	94.3	6.4337	59.5102
2025	10	22	3	40	0	11.8	0.1	0.9	27.55	93.5	6.4337	58.657
2025	10	22	3	50	0	11.8	0.1	0.9	27.39	94.6	6.4337	58.2304
2025	10	22	4	0	0	11.8	0.1	0.9	28.15	95.9	6.4337	59.7235
2025	10	22	4	10	0	11.8	0.1	0.9	28.51	91.8	6.4337	60.79
2025	10	22	4	20	0	11.8	0.1	0.9	27.96	96.2	6.4337	59.2969
2025	10	22	4	30	0	11.8	0.1	0.9	27.73	92.7	6.4337	59.0836
2025	10	22	4	40	0	11.8	0.1	0.9	27.55	93.5	6.4337	58.657
2025	10	22	4	50	0	11.8	0.1	0.9	27.25	93.6	6.4337	58.0171
2025	10	22	5	0	0	11.8	0.1	0.9	27.85	93.5	6.4337	59.2969
2025	10	22	5	10	0	11.8	0.1	0.9	26.45	93.7	6.4337	56.3107
2025	10	22	5	20	0	11.8	0.1	0.9	28.23	92.6	6.4337	60.1501
2025	10	22	5	30	0	11.8	0.1	0.9	28.23	92.8	6.4337	60.1501
2025	10	22	5	40	0	11.8	0.1	0.9	27.58	94.4	6.4337	58.657
2025	10	22	5	50	0	11.8	0.1	0.9	27.73	92.7	6.4337	59.0836
2025	10	22	6	0	0	11.8	0.1	0.9	27.71	91.9	6.4337	59.0836
2025	10	22	6	10	0	11.8	0.1	0.9	27.75	93.3	6.4337	59.0836
2025	10	22	6	20	0	11.8	0.1	0.9	27.63	92.5	6.4337	58.8703
2025	10	22	6	30	0	11.8	0.1	0.9	27.25	93.6	6.4337	58.0171
2025	10	22	6	40	0	11.8	0.1	0.9	27.92	95.3	6.4337	59.2969
2025	10	22	6	50	0	11.8	0.1	0.9	27.23	92.7	6.4337	58.0171
2025	10	22	7	0	0	11.8	0.1	0.9	27.13	92.5	6.4337	57.8038
2025	10	22	7	10	0	11.8	0.1	0.9	26.75	93.6	6.4337	56.9506
2025	10	22	7	20	0	11.8	0.1	0.9	27.96	93.9	6.4337	59.5102
2025	10	22	7	30	0	11.8	0.1	0.9	26.77	96.4	6.4337	56.7373
2025	10	22	7	40	0	11.8	0.1	0.9	27.02	92.1	6.4337	57.5905
2025	10	22	7	50	0	11.8	0.1	0.9	27.41	95.2	6.4337	58.2304
2025	10	22	8	0	0	11.8	0.1	0.9	27.49	94.6	6.4337	58.4437

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	22	8	10	0	11.8	0.1	0.9	27.63	92.7	6.4337	58.8703
2025	10	22	8	20	0	11.8	0.1	0.9	27.05	93.6	6.4337	57.5905
2025	10	22	8	30	0	11.8	0.1	0.9	27.53	92.5	6.4337	58.657
2025	10	22	8	40	0	11.8	0.1	0.9	26.97	94	6.4337	57.3772
2025	10	22	8	50	0	11.8	0.1	0.9	28.05	93.5	6.4337	59.7234
2025	10	22	9	0	0	12	0.1	0.9	26.54	93.2	6.4337	56.5239
2025	10	22	9	10	0	12	0.1	0.9	27.82	92.1	6.4337	59.2968
2025	10	22	9	20	0	12.2	0.1	0.9	27.72	92.3	6.4337	59.0835
2025	10	22	9	30	0	12.8	0.1	0.9	26.95	93.6	6.4337	57.3771
2025	10	22	9	40	0	13	0.1	0.9	27.62	92.1	6.4337	58.8701
2025	10	22	9	50	0	13.2	0.1	1	27.22	92.3	6.4398	58.0742
2025	10	22	10	0	0	13.2	0.1	0.9	27.64	93.1	6.4337	58.8701
2025	10	22	10	10	0	13.2	0.1	1	26.83	92.8	6.4398	57.2201
2025	10	22	10	20	0	12.8	0.1	0.9	26	90.9	6.4337	55.4573
2025	10	22	10	30	0	12.6	0.1	1	27.43	92.7	6.4398	58.5011
2025	10	22	10	40	0	12.6	0.1	1	27.45	93.6	6.4398	58.5011
2025	10	22	10	50	0	12.8	0.1	1	27.87	94.1	6.4398	59.3551
2025	10	22	11	0	0	13.6	0.1	1	26.22	92.2	6.4398	55.9389
2025	10	22	11	10	0	13	0.1	0.9	26.97	94.3	6.4337	57.3767
2025	10	22	11	20	0	14.2	0.1	1	27.63	92.7	6.4398	58.9279
2025	10	22	11	30	0	14.2	0.1	1	26.39	94.8	6.4398	56.1523
2025	10	22	11	40	0	14.2	0.1	1	26.18	94.6	6.4398	55.7252
2025	10	22	11	50	0	14.2	0.1	0.9	28.35	93.2	6.4337	60.3627
2025	10	22	12	0	0	14.2	0.1	0.9	27.27	94.2	6.4337	58.0164
2025	10	22	12	10	0	14.2	0.1	0.9	26.95	93.6	6.4276	57.3197
2025	10	22	12	20	0	14.2	0.1	0.9	27.12	92.3	6.4276	57.7459
2025	10	22	12	30	0	14.2	0.1	0.9	27.21	91.9	6.4276	57.9589
2025	10	22	12	40	0	14.2	0.1	0.9	27.73	92.5	6.4215	58.9659
2025	10	22	12	50	0	14.2	0.1	0.9	27.55	93.5	6.4215	58.5401
2025	10	22	13	0	0	14.2	0.1	0.9	26.72	91.9	6.4154	56.7808
2025	10	22	13	10	0	14.2	0.1	0.9	25.8	90.9	6.4154	54.8668
2025	10	22	13	20	0	14.2	0.1	0.9	27.23	92.5	6.4154	57.844
2025	10	22	13	30	0	14.2	0.1	0.9	27.75	93.5	6.4215	58.9656
2025	10	22	13	40	0	13.8	0.1	0.9	26.32	92.4	6.4154	55.93
2025	10	22	13	50	0	12.6	0.1	0.9	27.23	92.5	6.4093	57.7866
2025	10	22	14	0	0	12.4	0.1	0.9	27.57	94	6.4154	58.4819
2025	10	22	14	10	0	12.6	0.1	0.9	26.96	93.8	6.4154	57.2059
2025	10	22	14	20	0	12.8	0.1	0.9	26.26	93.9	6.4154	55.7172
2025	10	22	14	30	0	12.6	0.1	0.9	28.36	93.6	6.4093	60.1235
2025	10	22	14	40	0	12.6	0.1	0.9	26.56	93.9	6.4154	56.3552
2025	10	22	14	50	0	13	0.1	0.9	27.73	92.7	6.4093	58.8487
2025	10	22	15	0	0	14.2	0.1	0.9	26.91	91.5	6.4154	57.2058
2025	10	22	15	10	0	14.2	0.1	0.9	26.25	93.5	6.4154	55.7171
2025	10	22	15	20	0	14.2	0.1	0.9	26.81	91.3	6.4093	56.9366
2025	10	22	15	30	0	14.2	0.1	0.9	26.77	94.1	6.4093	56.7241
2025	10	22	15	40	0	11.6	0.1	0.9	25.7	95.1	6.4093	54.3872
2025	10	22	15	50	0	12	0.1	0.9	27.67	94.1	6.4093	58.6362
2025	10	22	16	0	0	12.6	0.1	0.9	27.24	92.9	6.4093	57.7864

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	22	16	10	0	13.8	0.1	0.9	26.72	92.4	6.4093	56.7241
2025	10	22	16	20	0	13.2	0.1	0.9	27.46	93.8	6.4093	58.2113
2025	10	22	16	30	0	12.8	0.1	0.9	27.35	93.6	6.4093	57.9988
2025	10	22	16	40	0	12.4	0.1	0.9	26.58	94.5	6.4093	56.2992
2025	10	22	16	50	0	12.2	0.1	0.9	27.07	94	6.4093	57.3615
2025	10	22	17	0	0	12.2	0.1	0.9	26.99	94.7	6.4093	57.149
2025	10	22	17	10	0	12.2	0.1	0.9	27.74	92.9	6.4093	58.8487
2025	10	22	17	20	0	12.2	0.1	0.9	26.69	94.7	6.4093	56.5117
2025	10	22	17	30	0	12.2	0.1	0.9	26.44	93	6.4093	56.0868
2025	10	22	17	40	0	12.2	0.1	0.9	26.76	93.9	6.4032	56.6679
2025	10	22	17	50	0	12.2	0.1	0.9	27.05	93.4	6.4093	57.3615
2025	10	22	18	0	0	12.2	0.1	0.9	27.33	92.7	6.4093	57.9989
2025	10	22	18	10	0	12.2	0.1	0.9	26.95	93.6	6.4032	57.0924
2025	10	22	18	20	0	12.2	0.1	0.9	26.31	91.7	6.4154	55.9298
2025	10	22	18	30	0	12.2	0.1	0.9	26.9	94.9	6.4093	56.9367
2025	10	22	18	40	0	12.2	0.1	0.9	27.35	93.4	6.4032	57.9414
2025	10	22	18	50	0	12	0.1	0.9	27.2	94.9	6.4032	57.5169
2025	10	22	19	0	0	12	0.1	0.9	26.91	91.5	6.4032	57.0925
2025	10	22	19	10	0	12	0.1	0.9	27.77	93.9	6.4032	58.7904
2025	10	22	19	20	0	12	0.1	0.9	27.53	92.7	6.4032	58.3659
2025	10	22	19	30	0	12	0.1	0.9	26.22	92.4	6.4032	55.6068
2025	10	22	19	40	0	12	0.1	0.9	26.86	93.8	6.4032	56.8803
2025	10	22	19	50	0	12	0.1	0.9	27.37	94	6.4032	57.9415
2025	10	22	20	0	0	12	0.1	0.9	26.35	93.7	6.4032	55.8191
2025	10	22	20	10	0	12	0.1	0.9	27.09	94.7	6.4032	57.3048
2025	10	22	20	20	0	12	0.1	0.9	27.14	93.2	6.4032	57.5171
2025	10	22	20	30	0	12	0.1	0.9	27.93	92.7	6.4032	59.215
2025	10	22	20	40	0	12	0.1	0.9	26.94	93.2	6.3971	57.036
2025	10	22	20	50	0	12	0.1	0.9	27.52	92.3	6.3971	58.3082
2025	10	22	21	0	0	12	0.1	0.9	26.33	95.7	6.3971	55.5518
2025	10	22	21	10	0	12	0.1	0.9	25.21	91.8	6.3971	53.4315
2025	10	22	21	20	0	12	0.1	0.9	27.79	94.5	6.3971	58.7323
2025	10	22	21	30	0	12	0.1	0.9	26.82	92.4	6.3971	56.8241
2025	10	22	21	40	0	12	0.1	0.9	26.26	93.9	6.3971	55.5519
2025	10	22	21	50	0	12	0.1	0.9	28.14	95.7	6.3971	59.3685
2025	10	22	22	0	0	12	0.1	0.9	26.61	91.7	6.391	56.344
2025	10	22	22	10	0	12	0.1	0.9	27.52	92.1	6.391	58.2504
2025	10	22	22	20	0	12	0.1	0.9	26.52	92.4	6.391	56.1322
2025	10	22	22	30	0	12	0.1	0.9	26.73	97.5	6.3971	56.1881
2025	10	22	22	40	0	12	0.1	0.9	26.93	92.6	6.391	56.9795
2025	10	22	22	50	0	12	0.1	0.9	26.21	91.7	6.391	55.4968
2025	10	22	23	0	0	12	0.1	0.9	27.75	93.5	6.391	58.6741
2025	10	22	23	10	0	12	0.1	0.9	27.46	93.8	6.391	58.0387
2025	10	22	23	20	0	12	0.1	0.9	26.72	92.1	6.391	56.556
2025	10	22	23	30	0	12	0.1	0.9	26.12	92.2	6.391	55.2851
2025	10	22	23	40	0	12	0.1	0.9	27.87	94.1	6.391	58.886
2025	10	22	23	50	0	12	0.1	0.9	27.79	94.5	6.391	58.6742
2025	10	23	0	0	0	12	0.1	0.9	26.84	93	6.391	56.7678

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	23	0	10	0	12	0.1	0.9	27.45	93.6	6.391	58.0388
2025	10	23	0	20	0	12	0.1	0.9	26.22	92	6.391	55.4969
2025	10	23	0	30	0	12	0.1	0.9	26.69	94.7	6.391	56.3442
2025	10	23	0	40	0	12	0.1	0.9	26.69	94.7	6.391	56.3442
2025	10	23	0	50	0	12	0.1	0.9	26.65	93.7	6.391	56.3442
2025	10	23	1	0	0	12	0.1	0.9	27.22	92.1	6.391	57.6152
2025	10	23	1	10	0	12	0.1	0.9	26.84	93	6.391	56.7679
2025	10	23	1	20	0	12	0.1	0.9	27.03	92.8	6.391	57.1915
2025	10	23	1	30	0	12	0.1	0.9	26.39	94.8	6.391	55.7088
2025	10	23	1	40	0	12	0.1	0.9	27.49	94.6	6.391	58.0388
2025	10	23	1	50	0	12	0.1	0.9	26.33	95.7	6.391	55.497
2025	10	23	2	0	0	12	0.1	0.9	27.69	94.6	6.391	58.4625
2025	10	23	2	10	0	12	0.1	0.9	26.64	93	6.391	56.3443
2025	10	23	2	20	0	12	0.1	0.9	27.25	93.6	6.391	57.6152
2025	10	23	2	30	0	12	0.1	0.9	27.89	94.5	6.391	58.8862
2025	10	23	2	40	0	12	0.1	0.9	27.34	92.9	6.391	57.8271
2025	10	23	2	50	0	12	0.1	0.9	26.84	93	6.391	56.768
2025	10	23	3	0	0	12	0.1	0.9	26.65	93.4	6.391	56.3443
2025	10	23	3	10	0	12	0.1	0.9	26.04	93.1	6.391	55.0734
2025	10	23	3	20	0	11.8	0.1	0.9	26.93	92.8	6.391	56.9798
2025	10	23	3	30	0	11.8	0.1	0.9	27.46	93.8	6.391	58.0389
2025	10	23	3	40	0	11.8	0.1	0.9	27.81	91.9	6.391	58.8862
2025	10	23	3	50	0	11.8	0.1	0.9	27.33	92.7	6.391	57.8271
2025	10	23	4	0	0	11.8	0.1	0.9	27.75	93.5	6.391	58.6744
2025	10	23	4	10	0	11.8	0.1	0.9	27.35	93.6	6.385	57.7696
2025	10	23	4	20	0	11.8	0.1	0.9	26.59	94.7	6.391	56.1326
2025	10	23	4	30	0	11.8	0.1	0.9	26.83	92.8	6.385	56.7116
2025	10	23	4	40	0	11.8	0.1	0.9	25.54	93.1	6.385	53.9606
2025	10	23	4	50	0	11.8	0.1	0.9	27.8	94.7	6.391	58.6744
2025	10	23	5	0	0	11.8	0.1	0.9	25.81	97.3	6.385	54.1723
2025	10	23	5	10	0	11.8	0.1	0.9	26.32	99	6.385	55.0187
2025	10	23	5	20	0	11.8	0.1	0.9	25.98	94.4	6.385	54.8071
2025	10	23	5	30	0	11.8	0.1	0.9	25.93	95.8	6.385	54.5955
2025	10	23	5	40	0	11.8	0.1	0.9	25.89	96.9	6.391	54.438
2025	10	23	5	50	0	11.8	0.1	0.9	25.89	94.7	6.385	54.5955
2025	10	23	6	0	0	11.8	0.1	0.9	26.09	94.8	6.385	55.0187
2025	10	23	6	10	0	11.8	0.1	0.9	25.76	94	6.385	54.3839
2025	10	23	6	20	0	11.8	0.1	0.9	27	94.9	6.385	56.9232
2025	10	23	6	30	0	11.8	0.1	0.9	27	97	6.385	56.7116
2025	10	23	6	40	0	11.8	0.1	0.9	26.48	94.3	6.385	55.8652
2025	10	23	6	50	0	11.8	0.1	0.9	26.15	93.5	6.385	55.2303
2025	10	23	7	0	0	11.8	0.1	0.9	26.37	94.1	6.385	55.6536
2025	10	23	7	10	0	11.8	0.1	0.9	27.85	93.5	6.385	58.8277
2025	10	23	7	20	0	11.8	0.1	0.9	25.66	94	6.385	54.1723
2025	10	23	7	30	0	11.8	0.1	0.9	27.04	93.2	6.385	57.1348
2025	10	23	7	40	0	11.8	0.1	0.9	25.58	96.7	6.385	53.7491
2025	10	23	7	50	0	11.8	0.1	0.9	27.35	93.6	6.385	57.7697
2025	10	23	8	0	0	12	0.1	0.9	26.47	94.1	6.385	55.8652

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	23	8	10	0	12.4	0.1	0.9	26.59	94.7	6.385	56.0768
2025	10	23	8	20	0	13.2	0.1	0.9	26.07	94.2	6.385	55.0188
2025	10	23	8	30	0	12.8	0.1	0.9	25.86	93.8	6.385	54.5956
2025	10	23	8	40	0	13	0.1	0.9	26.45	93.7	6.385	55.8652
2025	10	23	8	50	0	14.2	0.1	0.9	27.34	92.9	6.385	57.7697
2025	10	23	9	0	0	14.2	0.1	0.9	26.67	94.1	6.385	56.2884
2025	10	23	9	10	0	14.2	0.1	0.9	27.06	93.8	6.385	57.1349
2025	10	23	9	20	0	13	0.1	0.9	27.77	94.1	6.385	58.6161
2025	10	23	9	30	0	13	0.1	0.9	28.2	94.9	6.385	59.4626
2025	10	23	9	40	0	13.4	0.1	0.9	26.55	93.5	6.385	56.0768
2025	10	23	9	50	0	13.4	0.1	0.9	26.8	94.9	6.385	56.5
2025	10	23	10	0	0	13.6	0.1	0.9	26.62	91.9	6.385	56.2883
2025	10	23	10	10	0	13.6	0.1	0.9	27.45	93.6	6.385	57.9812
2025	10	23	10	20	0	13.8	0.1	0.9	27.42	95.4	6.385	57.7696
2025	10	23	10	30	0	14.2	0.1	0.9	26.73	92.8	6.385	56.4999
2025	10	23	10	40	0	14.2	0.1	0.9	27.46	93.8	6.385	57.9811
2025	10	23	10	50	0	14.2	0.1	0.9	26.97	94.3	6.391	56.9797
2025	10	23	11	0	0	14.2	0.1	0.9	25.26	93.9	6.391	53.3787
2025	10	23	11	10	0	14.2	0.1	0.9	27.94	93.1	6.391	59.0978
2025	10	23	11	20	0	14.2	0.1	0.9	26.68	94.3	6.391	56.3441
2025	10	23	11	30	0	14.2	0.1	0.9	27.52	92.1	6.391	58.2505
2025	10	23	11	40	0	14.2	0.1	0.9	27.12	95.5	6.391	57.1913
2025	10	23	11	50	0	14.2	0.1	0.9	26.85	93.4	6.391	56.7676
2025	10	23	12	0	0	14.2	0.1	0.9	26.55	93.5	6.391	56.1321
2025	10	23	12	10	0	14.2	0.1	0.9	27.22	95.3	6.391	57.403
2025	10	23	12	20	0	13.8	0.1	0.9	26.19	94.8	6.391	55.2848
2025	10	23	12	30	0	14.2	0.1	0.9	27.3	94.8	6.391	57.6147
2025	10	23	12	40	0	14.2	0.1	0.9	27.23	92.5	6.391	57.6147
2025	10	23	12	50	0	14.2	0.1	0.9	27.05	93.4	6.391	57.191
2025	10	23	13	0	0	14.2	0.1	0.9	27.13	92.7	6.391	57.4028
2025	10	23	13	10	0	14.2	0.1	0.9	26.53	92.8	6.391	56.1318
2025	10	23	13	20	0	14	0.1	0.9	26.61	95.2	6.391	56.1318
2025	10	23	13	30	0	14.2	0.1	0.9	27.28	94.4	6.391	57.6145
2025	10	23	13	40	0	14.2	0.1	0.9	27.22	92.3	6.391	57.6144
2025	10	23	13	50	0	14.2	0.1	0.9	27.39	94.6	6.391	57.8262
2025	10	23	14	0	0	14.2	0.1	0.9	26.54	93.2	6.391	56.1316
2025	10	23	14	10	0	14.2	0.1	0.9	26.31	91.5	6.391	55.708
2025	10	23	14	20	0	13.6	0.1	0.9	28.26	93.9	6.391	59.7325
2025	10	23	14	30	0	13.6	0.1	0.9	26.02	92	6.391	55.0725
2025	10	23	14	40	0	13.6	0.1	0.9	27.14	93.2	6.391	57.4024
2025	10	23	14	50	0	13.6	0.1	0.9	27.75	93.3	6.391	58.6733
2025	10	23	15	0	0	13.6	0.1	0.9	26.92	92.3	6.391	56.9787
2025	10	23	15	10	0	13.6	0.1	0.9	25.53	92.7	6.391	54.0133
2025	10	23	15	20	0	13.6	0.1	0.9	27.81	91.9	6.391	58.885
2025	10	23	15	30	0	13.6	0.1	0.9	26.96	93.8	6.391	56.9786
2025	10	23	15	40	0	13.6	0.1	0.9	27.25	93.4	6.391	57.6141
2025	10	23	15	50	0	13.6	0.1	0.9	27.31	91.9	6.391	57.8259
2025	10	23	16	0	0	13.6	0.1	0.9	27.8	91	6.391	58.885

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	23	16	10	0	13.6	0.1	0.9	27.83	92.5	6.391	58.8849
2025	10	23	16	20	0	13.6	0.1	0.9	25.73	92.7	6.391	54.4368
2025	10	23	16	30	0	13.6	0.1	0.9	27.11	91.9	6.391	57.4022
2025	10	23	16	40	0	13.6	0.1	0.9	26.62	92.4	6.391	56.3431
2025	10	23	16	50	0	13.6	0.1	0.9	26.53	92.8	6.391	56.1313
2025	10	23	17	0	0	13.6	0.1	0.9	27.06	93.8	6.391	57.1904
2025	10	23	17	10	0	13.6	0.1	0.9	26.41	91.3	6.391	55.9195
2025	10	23	17	20	0	13	0.1	0.9	28.43	92.8	6.391	60.1558
2025	10	23	17	30	0	12.2	0.1	0.9	27.03	92.5	6.391	57.1904
2025	10	23	17	40	0	12.2	0.1	0.9	27.01	91.3	6.391	57.1904
2025	10	23	17	50	0	12.2	0.1	0.9	28.12	92	6.391	59.5204
2025	10	23	18	0	0	12.2	0.1	0.9	26.82	92.1	6.385	56.7103
2025	10	23	18	10	0	12.2	0.1	0.9	26.97	94	6.391	56.9786
2025	10	23	18	20	0	12.2	0.1	0.9	26.13	92.6	6.385	55.2291
2025	10	23	18	30	0	12.2	0.1	0.9	26.52	92.2	6.385	56.0755
2025	10	23	18	40	0	12.2	0.1	0.9	27.48	94.4	6.385	57.98
2025	10	23	18	50	0	12.2	0.1	0.9	26.85	93.6	6.385	56.7104
2025	10	23	19	0	0	12.2	0.1	0.9	27.01	95.1	6.385	56.922
2025	10	23	19	10	0	12.2	0.1	0.9	27.16	96.1	6.385	57.1336
2025	10	23	19	20	0	12.2	0.1	0.9	26.52	91.9	6.385	56.0756
2025	10	23	19	30	0	12.2	0.1	0.9	25.92	92.4	6.385	54.806
2025	10	23	19	40	0	12.2	0.1	0.9	27.32	95.5	6.385	57.5569
2025	10	23	19	50	0	12	0.1	0.9	27.36	93.8	6.3789	57.711
2025	10	23	20	0	0	12	0.1	0.9	27.1	90.8	6.3789	57.2883
2025	10	23	20	10	0	12	0.1	0.9	27.86	93.7	6.385	58.8266
2025	10	23	20	20	0	12	0.1	0.9	27.19	94.6	6.3789	57.2883
2025	10	23	20	30	0	12	0.1	0.9	27.08	94.4	6.3789	57.077
2025	10	23	20	40	0	12	0.1	0.9	27.73	92.7	6.3789	58.5568
2025	10	23	20	50	0	12	0.1	0.9	26.94	93.2	6.3789	56.8656
2025	10	23	21	0	0	12	0.1	0.9	26.41	91.5	6.3789	55.8087
2025	10	23	21	10	0	12	0.1	0.9	27.33	92.5	6.3789	57.7113
2025	10	23	21	20	0	12	0.1	0.9	26.81	91.7	6.3789	56.6543
2025	10	23	21	30	0	12	0.1	0.9	26.91	91.5	6.3728	56.8091
2025	10	23	21	40	0	12	0.1	0.9	26.74	93	6.3728	56.3867
2025	10	23	21	50	0	12	0.1	0.9	26.87	94.3	6.3728	56.598
2025	10	23	22	0	0	12	0.1	0.9	27.43	92.5	6.3728	57.8651
2025	10	23	22	10	0	12	0.1	0.9	27.31	91.7	6.3728	57.654
2025	10	23	22	20	0	12	0.1	0.9	26.41	91.5	6.3728	55.7533
2025	10	23	22	30	0	12	0.1	0.9	26.82	91.9	6.3728	56.5981
2025	10	23	22	40	0	12	0.1	0.9	26.78	94.5	6.3728	56.3869
2025	10	23	22	50	0	12	0.1	0.9	26.4	91.1	6.3728	55.7534
2025	10	23	23	0	0	12	0.1	0.9	27.54	92.9	6.3728	58.0765
2025	10	23	23	10	0	12	0.1	0.9	26.75	93.6	6.3728	56.387
2025	10	23	23	20	0	12	0.1	0.9	26.62	92.4	6.3728	56.1759
2025	10	23	23	30	0	12	0.1	0.9	27.73	92.5	6.3728	58.499
2025	10	23	23	40	0	12	0.1	0.9	26.64	93.2	6.3728	56.176
2025	10	23	23	50	0	12	0.1	0.9	26.64	93.2	6.3728	56.176
2025	10	24	0	0	0	12	0.1	0.9	26.35	93.5	6.3728	55.5425

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	24	0	10	0	12	0.1	0.9	26.2	95	6.3728	55.1201
2025	10	24	0	20	0	12	0.1	0.9	25.74	93.1	6.3728	54.2754
2025	10	24	0	30	0	12	0.1	0.9	26.31	91.3	6.3728	55.5426
2025	10	24	0	40	0	12	0.1	0.9	26.85	93.6	6.3728	56.5985
2025	10	24	0	50	0	12	0.1	0.9	27.48	94.4	6.3728	57.8657
2025	10	24	1	0	0	12	0.1	0.9	26.59	94.7	6.3728	55.965
2025	10	24	1	10	0	12	0.1	0.9	26.71	95.2	6.3728	56.1762
2025	10	24	1	20	0	12	0.1	0.9	25.93	95.8	6.3728	54.4868
2025	10	24	1	30	0	12	0.1	0.9	26.71	95.2	6.3667	56.1203
2025	10	24	1	40	0	12	0.1	0.9	26.12	95.5	6.3667	54.8544
2025	10	24	1	50	0	12	0.1	0.9	27.36	93.8	6.3728	57.6547
2025	10	24	2	0	0	12	0.1	0.9	26.13	92.9	6.3667	55.0655
2025	10	24	2	10	0	12	0.1	0.9	26.19	94.8	6.3667	55.0655
2025	10	24	2	20	0	12	0.1	0.9	27.15	93.4	6.3667	57.1753
2025	10	24	2	30	0	12	0.1	0.9	25.92	92.4	6.3667	54.6436
2025	10	24	2	40	0	12	0.1	0.9	26.93	92.8	6.3667	56.7534
2025	10	24	2	50	0	12	0.1	0.9	26.54	93.2	6.3667	55.9095
2025	10	24	3	0	0	12	0.1	0.9	27.21	91.5	6.3667	57.3864
2025	10	24	3	10	0	11.8	0.1	0.9	25.23	93	6.3667	53.1669
2025	10	24	3	20	0	11.8	0.1	0.9	26.52	92.2	6.3667	55.9096
2025	10	24	3	30	0	11.8	0.1	0.9	26.63	92.8	6.3667	56.1206
2025	10	24	3	40	0	11.8	0.1	0.9	26.64	93	6.3667	56.1207
2025	10	24	3	50	0	11.8	0.1	0.9	26.36	93.9	6.3667	55.4877
2025	10	24	4	0	0	11.8	0.1	0.9	26.76	93.9	6.3667	56.3317
2025	10	24	4	10	0	11.8	0.1	0.9	27.65	93.3	6.3667	58.2305
2025	10	24	4	20	0	11.8	0.1	0.9	27.17	94.2	6.3667	57.1757
2025	10	24	4	30	0	11.8	0.1	0.9	27.97	94.1	6.3667	58.8635
2025	10	24	4	40	0	11.8	0.1	0.9	26.94	93	6.3667	56.7537
2025	10	24	4	50	0	11.8	0.1	0.9	26.94	93	6.3667	56.7538
2025	10	24	5	0	0	11.8	0.1	0.9	27.59	94.6	6.3667	58.0197
2025	10	24	5	10	0	11.8	0.1	0.9	26.62	91.9	6.3667	56.1209
2025	10	24	5	20	0	11.8	0.1	0.9	26.27	94.1	6.3667	55.277
2025	10	24	5	30	0	11.8	0.1	0.9	26.81	95.1	6.3667	56.3319
2025	10	24	5	40	0	11.8	0.1	0.9	26.68	94.5	6.3667	56.1209
2025	10	24	5	50	0	11.8	0.1	0.9	26.65	93.7	6.3667	56.121
2025	10	24	6	0	0	11.8	0.1	0.9	25.91	91.8	6.3667	54.6441
2025	10	24	6	10	0	11.8	0.1	0.9	26.92	95.3	6.3667	56.543
2025	10	24	6	20	0	11.8	0.1	0.9	26.12	95.5	6.3667	54.8551
2025	10	24	6	30	0	11.8	0.1	0.9	26.29	94.8	6.3667	55.2771
2025	10	24	6	40	0	11.8	0.1	0.9	27.13	92.7	6.3667	57.176
2025	10	24	6	50	0	11.8	0.1	0.9	27.35	93.6	6.3667	57.598
2025	10	24	7	0	0	11.8	0.1	0.9	26.66	93.9	6.3667	56.1211
2025	10	24	7	10	0	11.8	0.1	0.9	27.04	93	6.3667	56.9651
2025	10	24	7	20	0	11.8	0.1	0.9	26.45	93.7	6.3667	55.6992
2025	10	24	7	30	0	11.8	0.1	0.9	26.88	94.5	6.3667	56.5431
2025	10	24	7	40	0	11.8	0.1	0.9	26.74	93	6.3667	56.3322
2025	10	24	7	50	0	11.8	0.1	0.9	26.39	97	6.3667	55.2773
2025	10	24	8	0	0	12	0.1	0.9	26.59	94.7	6.3667	55.9102

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	24	8	10	0	12.4	0.1	0.9	26.48	94.5	6.3606	55.6437
2025	10	24	8	20	0	12.6	0.1	0.9	27.74	95.8	6.3667	58.2311
2025	10	24	8	30	0	12.8	0.1	0.9	27.05	93.6	6.3667	56.9652
2025	10	24	8	40	0	12.8	0.1	0.9	26.42	92.2	6.3606	55.6437
2025	10	24	8	50	0	13	0.1	0.9	26.75	93.4	6.3667	56.3323
2025	10	24	9	0	0	13	0.1	0.9	26.84	93	6.3606	56.4868
2025	10	24	9	10	0	13	0.1	0.9	26.73	92.8	6.3667	56.3322
2025	10	24	9	20	0	13	0.1	0.9	26.98	94.5	6.3667	56.7542
2025	10	24	9	30	0	13	0.1	0.9	27.28	94.4	6.3667	57.3871
2025	10	24	9	40	0	13.2	0.1	0.9	27.08	94.4	6.3667	56.9651
2025	10	24	9	50	0	13.2	0.1	0.9	26.99	94.7	6.3667	56.7541
2025	10	24	10	0	0	13.2	0.1	0.9	26.6	95	6.3667	55.9102
2025	10	24	10	10	0	13.4	0.1	0.9	25.26	94.1	6.3667	53.1674
2025	10	24	10	20	0	13.6	0.1	0.9	26.16	93.9	6.3667	55.0662
2025	10	24	10	30	0	13.6	0.1	0.9	27.07	94	6.3667	56.965
2025	10	24	10	40	0	13.6	0.1	0.9	27.12	95.3	6.3667	56.9649
2025	10	24	10	50	0	13.4	0.1	0.9	27.42	92.3	6.3667	57.8088
2025	10	24	11	0	0	13.6	0.1	0.9	26	91.1	6.3667	54.855
2025	10	24	11	10	0	13.4	0.1	0.9	27.22	92.3	6.3667	57.3868
2025	10	24	11	20	0	13.4	0.1	0.9	27.1	94.9	6.3667	56.9647
2025	10	24	11	30	0	13.6	0.1	0.9	27.16	93.8	6.3667	57.1757
2025	10	24	11	40	0	13.6	0.1	0.9	26.74	95.8	6.3667	56.1207
2025	10	24	11	50	0	13.4	0.1	0.9	27.15	93.6	6.3667	57.1755
2025	10	24	12	0	0	13.8	0.1	0.9	27.95	93.5	6.3728	58.9221
2025	10	24	12	10	0	13.8	0.1	0.9	26.71	91.5	6.3728	56.3878
2025	10	24	12	20	0	13.8	0.1	0.9	26.47	94.1	6.3728	55.7541
2025	10	24	12	30	0	13.4	0.1	0.9	28.15	93.5	6.3728	59.3443
2025	10	24	12	40	0	13.4	0.1	0.9	27.68	94.4	6.3728	58.2883
2025	10	24	12	50	0	13.4	0.1	0.9	26.85	93.6	6.3728	56.5987
2025	10	24	13	0	0	13.4	0.1	0.9	26.53	92.6	6.3728	55.9651
2025	10	24	13	10	0	13.4	0.1	0.9	26.95	93.6	6.3728	56.8098
2025	10	24	13	20	0	13.4	0.1	0.9	26.93	92.6	6.3728	56.8097
2025	10	24	13	30	0	13.4	0.1	0.9	27.12	95.5	6.3728	57.0209
2025	10	24	13	40	0	13.6	0.1	0.9	26.74	93.2	6.3728	56.3873
2025	10	24	13	50	0	13.6	0.1	0.9	27.45	93.6	6.3728	57.8655
2025	10	24	14	0	0	13.6	0.1	0.9	27.05	93.4	6.3728	57.0207
2025	10	24	14	10	0	13.6	0.1	0.9	25.52	92	6.3728	53.8529
2025	10	24	14	20	0	13.6	0.1	0.9	26.28	94.4	6.3728	55.3311
2025	10	24	14	30	0	13.6	0.1	0.9	27.05	95.9	6.3667	56.7527
2025	10	24	14	40	0	13.6	0.1	0.9	27.02	92.1	6.3606	56.9068
2025	10	24	14	50	0	13.6	0.1	0.9	28.23	92.6	6.3606	59.436
2025	10	24	15	0	0	13.6	0.1	0.9	27.12	92.3	6.3606	57.1175
2025	10	24	15	10	0	13.6	0.1	0.9	27.41	95	6.3606	57.539
2025	10	24	15	20	0	13.4	0.1	0.9	26.77	94.3	6.3606	56.2744
2025	10	24	15	30	0	13.4	0.1	0.9	27.31	95.3	6.3545	57.2709
2025	10	24	15	40	0	13.4	0.1	0.9	25.61	91.6	6.3545	53.902
2025	10	24	15	50	0	13.4	0.1	0.9	26.93	97.5	6.3545	56.218
2025	10	24	16	0	0	13.4	0.1	0.9	27.92	95.3	6.3545	58.5341

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	24	16	10	0	13.4	0.1	0.9	27.26	93.8	6.3484	57.2135
2025	10	24	16	20	0	13.4	0.1	0.9	27.2	94.9	6.3484	57.0031
2025	10	24	16	30	0	13.4	0.1	0.9	26.86	93.8	6.3484	56.3721
2025	10	24	16	40	0	13.4	0.1	0.9	27.71	95.2	6.3484	58.0548
2025	10	24	16	50	0	13.4	0.1	0.9	27.45	93.6	6.3484	57.6341
2025	10	24	17	0	0	13.6	0.1	0.9	26.83	92.6	6.3484	56.372
2025	10	24	17	10	0	13.6	0.1	0.9	27.74	95.8	6.3484	58.0548
2025	10	24	17	20	0	12.4	0.1	0.9	27	94.9	6.3484	56.5823
2025	10	24	17	30	0	12.2	0.1	0.9	27.27	94	6.3484	57.2134
2025	10	24	17	40	0	12.2	0.1	0.9	26.25	93.5	6.3484	55.1099
2025	10	24	17	50	0	12.2	0.1	0.9	27.54	92.9	6.3484	57.8444
2025	10	24	18	0	0	12.2	0.1	0.9	26.58	94.5	6.3484	55.741
2025	10	24	18	10	0	12.2	0.1	0.9	27.06	93.8	6.3484	56.7927
2025	10	24	18	20	0	12.2	0.1	0.9	27.46	93.8	6.3484	57.6341
2025	10	24	18	30	0	12.2	0.1	0.9	26.65	93.7	6.3484	55.9513
2025	10	24	18	40	0	12.2	0.1	0.9	26.84	95.8	6.3484	56.1617
2025	10	24	18	50	0	12.2	0.1	0.9	27.28	94.4	6.3484	57.2134
2025	10	24	19	0	0	12.2	0.1	0.9	26.53	92.8	6.3484	55.741
2025	10	24	19	10	0	12.2	0.1	0.9	27.07	94	6.3484	56.7928
2025	10	24	19	20	0	12.2	0.1	0.9	27.45	93.6	6.3484	57.6342
2025	10	24	19	30	0	12.2	0.1	0.9	26.42	92	6.3484	55.5308
2025	10	24	19	40	0	12.2	0.1	0.9	27.54	95.8	6.3423	57.5765
2025	10	24	19	50	0	12.2	0.1	0.9	28.07	94.1	6.3423	58.8373
2025	10	24	20	0	0	12	0.1	0.9	27.26	93.8	6.3423	57.1563
2025	10	24	20	10	0	12	0.1	0.9	27.44	93.1	6.3423	57.5766
2025	10	24	20	20	0	12	0.1	0.9	26.85	93.4	6.3423	56.3158
2025	10	24	20	30	0	12	0.1	0.9	26.54	93	6.3423	55.6855
2025	10	24	20	40	0	12	0.1	0.9	27.45	93.6	6.3423	57.5767
2025	10	24	20	50	0	12	0.1	0.9	26.64	93	6.3423	55.8957
2025	10	24	21	0	0	12	0.1	0.9	27.55	93.5	6.3423	57.7869
2025	10	24	21	10	0	12	0.1	0.9	26.93	92.8	6.3362	56.4695
2025	10	24	21	20	0	12	0.1	0.9	26.04	93.1	6.3362	54.5802
2025	10	24	21	30	0	12	0.1	0.9	27.37	94	6.3362	57.3092
2025	10	24	21	40	0	12	0.1	0.9	26.42	92	6.3362	55.4199
2025	10	24	21	50	0	12	0.1	0.9	26.43	92.8	6.3362	55.42
2025	10	24	22	0	0	12	0.1	0.9	26.57	94.1	6.3362	55.6299
2025	10	24	22	10	0	12	0.1	0.9	27.02	92.1	6.3362	56.6796
2025	10	24	22	20	0	12	0.1	0.9	25.21	91.4	6.3362	52.901
2025	10	24	22	30	0	12	0.1	0.9	27.29	94.6	6.3362	57.0995
2025	10	24	22	40	0	12	0.1	0.9	27.32	92.3	6.3362	57.3094
2025	10	24	22	50	0	12	0.1	0.9	25.65	93.6	6.3362	53.7408
2025	10	24	23	0	0	12	0.1	0.9	27.03	92.8	6.3362	56.6797
2025	10	24	23	10	0	12	0.1	0.9	26.31	91.3	6.3362	55.2103
2025	10	24	23	20	0	12	0.1	0.9	26.32	92	6.3362	55.2103
2025	10	24	23	30	0	12	0.1	0.9	27.95	93.5	6.3362	58.5691
2025	10	24	23	40	0	12	0.1	0.9	26.71	95.2	6.3362	55.8402
2025	10	24	23	50	0	12	0.1	0.9	27.41	95	6.3362	57.3097
2025	10	25	0	0	0	12	0.1	0.9	26.83	92.6	6.3362	56.2601

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	25	0	10	0	12	0.1	0.9	26.06	93.7	6.3362	54.5807
2025	10	25	0	20	0	12	0.1	0.9	27.06	93.8	6.3362	56.68
2025	10	25	0	30	0	12	0.1	0.9	26.98	94.5	6.3362	56.4701
2025	10	25	0	40	0	12	0.1	0.9	27.34	93.1	6.3423	57.3673
2025	10	25	0	50	0	12	0.1	0.9	26.35	93.7	6.3423	55.266
2025	10	25	1	0	0	12	0.1	0.9	27.33	92.5	6.3423	57.3674
2025	10	25	1	10	0	12	0.1	0.9	26.75	93.6	6.3423	56.1066
2025	10	25	1	20	0	12	0.1	0.9	26.17	94.2	6.3423	54.8458
2025	10	25	1	30	0	12	0.1	0.9	25.87	94.2	6.3484	54.2698
2025	10	25	1	40	0	12	0.1	0.9	27.5	95	6.3484	57.6354
2025	10	25	1	50	0	12	0.1	0.9	27.86	93.7	6.3484	58.4768
2025	10	25	2	0	0	12	0.1	0.9	26.74	93.2	6.3484	56.163
2025	10	25	2	10	0	12	0.1	0.9	27.74	92.9	6.3484	58.2665
2025	10	25	2	20	0	12	0.1	0.9	26.26	93.7	6.3484	55.1113
2025	10	25	2	30	0	12	0.1	0.9	25.69	94.9	6.3484	53.8492
2025	10	25	2	40	0	12	0.1	0.9	28.33	95.5	6.3484	59.3183
2025	10	25	2	50	0	12	0.1	0.9	27.03	95.5	6.3484	56.5838
2025	10	25	3	0	0	11.8	0.1	0.9	26.97	94	6.3484	56.5838
2025	10	25	3	10	0	11.8	0.1	0.9	26.6	90.2	6.3484	55.9528
2025	10	25	3	20	0	11.8	0.1	0.9	25.83	92.9	6.3484	54.2701
2025	10	25	3	30	0	11.8	0.1	0.9	26.65	93.4	6.3484	55.9529
2025	10	25	3	40	0	11.8	0.1	0.9	27.05	93.6	6.3484	56.7943
2025	10	25	3	50	0	11.8	0.1	0.9	26.67	94.1	6.3484	55.9529
2025	10	25	4	0	0	11.8	0.1	0.9	26.16	93.7	6.3484	54.9012
2025	10	25	4	10	0	11.8	0.1	0.9	26.74	95.8	6.3545	56.009
2025	10	25	4	20	0	11.8	0.1	0.9	26.94	93.2	6.3484	56.584
2025	10	25	4	30	0	11.8	0.1	0.9	26.53	92.8	6.3545	55.7984
2025	10	25	4	40	0	11.8	0.1	0.9	25.73	92.9	6.3484	54.0598
2025	10	25	4	50	0	11.8	0.1	0.9	27.48	94.4	6.3484	57.6358
2025	10	25	5	0	0	11.8	0.1	0.9	26.23	92.8	6.3484	55.1116
2025	10	25	5	10	0	11.8	0.1	0.9	26.72	95.4	6.3545	56.009
2025	10	25	5	20	0	11.8	0.1	0.9	27.18	94.4	6.3484	57.0047
2025	10	25	5	30	0	11.8	0.1	0.9	27.55	96	6.3545	57.6935
2025	10	25	5	40	0	11.8	0.1	0.9	26.98	94.5	6.3484	56.5841
2025	10	25	5	50	0	11.8	0.1	0.9	27.54	92.9	6.3484	57.8462
2025	10	25	6	0	0	11.8	0.1	0.9	28.05	93.3	6.3484	58.8979
2025	10	25	6	10	0	11.8	0.1	0.9	26.98	94.5	6.3545	56.6408
2025	10	25	6	20	0	11.8	0.1	0.9	26.26	93.7	6.3484	55.1117
2025	10	25	6	30	0	11.8	0.1	0.9	26.77	94.1	6.3484	56.1634
2025	10	25	6	40	0	11.8	0.1	0.9	27.68	94.4	6.3484	58.0566
2025	10	25	6	50	0	11.8	0.1	0.9	26.85	93.6	6.3484	56.3738
2025	10	25	7	0	0	11.8	0.1	0.9	27.25	93.4	6.3545	57.2725
2025	10	25	7	10	0	11.8	0.1	0.9	26.13	92.9	6.3545	54.9563
2025	10	25	7	20	0	11.8	0.1	0.9	26.08	94.4	6.3545	54.7458
2025	10	25	7	30	0	11.8	0.1	0.9	26.94	93.2	6.3545	56.6408
2025	10	25	7	40	0	11.8	0.1	0.9	27.12	92.1	6.3545	57.062
2025	10	25	7	50	0	11.8	0.1	0.9	26.53	92.8	6.3545	55.7986
2025	10	25	8	0	0	11.8	0.1	0.9	26.82	91.9	6.3545	56.4303

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	25	8	10	0	11.8	0.1	0.9	26.55	93.7	6.3545	55.7986
2025	10	25	8	20	0	11.8	0.1	0.9	27.65	93.5	6.3545	58.1148
2025	10	25	8	30	0	11.8	0.1	0.9	25.03	92.7	6.3545	52.6402
2025	10	25	8	40	0	11.8	0.1	0.9	26.91	91.7	6.3484	56.5842
2025	10	25	8	50	0	11.8	0.1	0.9	26.65	93.7	6.3545	56.0092
2025	10	25	9	0	0	12	0.1	0.9	27.21	91.7	6.3545	57.2726
2025	10	25	9	10	0	12	0.1	0.9	27.6	96.9	6.3545	57.6937
2025	10	25	9	20	0	12	0.1	0.9	26.01	91.3	6.3545	54.7458
2025	10	25	9	30	0	12	0.1	0.9	26.32	92.2	6.3545	55.3775
2025	10	25	9	40	0	12.2	0.1	0.9	26.77	94.1	6.3545	56.2198
2025	10	25	9	50	0	12.2	0.1	0.9	26.65	93.7	6.3545	56.0092
2025	10	25	10	0	0	12.2	0.1	0.9	26.72	92.4	6.3545	56.2197
2025	10	25	10	10	0	12.6	0.1	0.9	26.85	93.6	6.3545	56.4303
2025	10	25	10	20	0	12.8	0.1	0.9	26.77	94.1	6.3545	56.2197
2025	10	25	10	30	0	13	0.1	0.9	26.27	94.1	6.3545	55.1669
2025	10	25	10	40	0	13	0.1	0.9	26.14	93.1	6.3545	54.9563
2025	10	25	10	50	0	13.2	0.1	0.9	26.87	94.3	6.3545	56.4302
2025	10	25	11	0	0	13.2	0.1	0.9	26.74	93	6.3545	56.2196
2025	10	25	11	10	0	13.2	0.1	0.9	26.97	96.4	6.3545	56.4301
2025	10	25	11	20	0	13	0.1	0.9	26.72	92.4	6.3545	56.2195
2025	10	25	11	30	0	13.2	0.1	0.9	27.07	94	6.3545	56.8511
2025	10	25	11	40	0	13	0.1	0.9	26.42	92	6.3545	55.5878
2025	10	25	11	50	0	13.2	0.1	0.9	27.76	96.2	6.3606	58.1726
2025	10	25	12	0	0	13.6	0.1	0.9	26.86	93.8	6.3545	56.4299
2025	10	25	12	10	0	13.6	0.1	0.9	27.83	92.5	6.3545	58.5354
2025	10	25	12	20	0	13.6	0.1	0.9	28.1	90.4	6.3545	59.167
2025	10	25	12	30	0	14	0.1	0.9	26.98	94.5	6.3606	56.697
2025	10	25	12	40	0	13.8	0.1	0.9	26.85	93.6	6.3545	56.4297
2025	10	25	12	50	0	14.2	0.1	0.9	27.25	93.6	6.3606	57.3291
2025	10	25	13	0	0	14.2	0.1	0.9	27.29	94.6	6.3606	57.3291
2025	10	25	13	10	0	14.2	0.1	0.9	26.46	93.9	6.3545	55.5873
2025	10	25	13	20	0	14.2	0.1	0.9	25.54	93.1	6.3545	53.6922
2025	10	25	13	30	0	14.2	0.1	0.9	26.64	93	6.3484	55.9522
2025	10	25	13	40	0	14.2	0.1	0.9	27.65	93.5	6.3423	57.9975
2025	10	25	13	50	0	14.2	0.1	0.9	26.95	93.4	6.3423	56.5265
2025	10	25	14	0	0	14.2	0.1	0.9	28.32	95.3	6.3423	59.2582
2025	10	25	14	10	0	14.2	0.1	0.9	27.37	94	6.3423	57.367
2025	10	25	14	20	0	14.2	0.1	0.9	27.27	94.2	6.3484	57.2141
2025	10	25	14	30	0	14.2	0.1	0.9	27.04	95.7	6.3423	56.5263
2025	10	25	14	40	0	14.2	0.1	0.9	26.55	93.7	6.3423	55.6857
2025	10	25	14	50	0	14.2	0.1	0.9	26.12	92	6.3362	54.7902
2025	10	25	15	0	0	13.8	0.1	0.9	27.07	94	6.3362	56.6795
2025	10	25	15	10	0	13.8	0.1	0.9	28.46	93.8	6.3362	59.6184
2025	10	25	15	20	0	13.6	0.1	0.9	26.91	95.1	6.3362	56.2596
2025	10	25	15	30	0	13.6	0.1	0.9	27.58	94.4	6.3362	57.729
2025	10	25	15	40	0	14.2	0.1	0.9	26.85	93.6	6.3362	56.2595
2025	10	25	15	50	0	14	0.1	0.9	27.17	94.2	6.3362	56.8893
2025	10	25	16	0	0	13.6	0.1	0.9	27.04	93.2	6.3362	56.6793

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	25	16	10	0	13.6	0.1	0.9	26.33	92.8	6.3362	55.2098
2025	10	25	16	20	0	13	0.1	0.9	26.46	93.9	6.3362	55.4198
2025	10	25	16	30	0	13.2	0.1	0.9	27.97	94.1	6.3362	58.5686
2025	10	25	16	40	0	13.2	0.1	0.9	27.25	93.6	6.3362	57.0991
2025	10	25	16	50	0	12.8	0.1	0.9	27.21	95.1	6.3362	56.8892
2025	10	25	17	0	0	12.6	0.1	0.9	26.85	93.4	6.3362	56.2594
2025	10	25	17	10	0	12.6	0.1	0.9	26.96	93.8	6.3362	56.4693
2025	10	25	17	20	0	12.4	0.1	0.9	27.54	92.9	6.3362	57.7288
2025	10	25	17	30	0	12.2	0.1	0.9	26.43	92.8	6.3362	55.4197
2025	10	25	17	40	0	12.2	0.1	0.9	27.56	93.7	6.3362	57.7288
2025	10	25	17	50	0	12.2	0.1	0.9	26.48	94.3	6.3362	55.4197
2025	10	25	18	0	0	12.2	0.1	0.9	25.54	93.1	6.3301	53.4766
2025	10	25	18	10	0	12.2	0.1	0.9	26.87	94.1	6.3362	56.2593
2025	10	25	18	20	0	12.2	0.1	0.9	27.12	92.1	6.3362	56.8891
2025	10	25	18	30	0	12.2	0.1	0.9	25.83	95.8	6.3362	53.9502
2025	10	25	18	40	0	12.2	0.1	0.9	27.07	94	6.3362	56.6792
2025	10	25	18	50	0	12.2	0.1	0.9	26.89	94.7	6.3362	56.2594
2025	10	25	19	0	0	12.2	0.1	0.9	26.75	93.4	6.3362	56.0495
2025	10	25	19	10	0	12	0.1	0.9	26.27	94.1	6.3362	54.9999
2025	10	25	19	20	0	12	0.1	0.9	26.36	93.9	6.3301	55.1544
2025	10	25	19	30	0	12	0.1	0.9	26.11	95.3	6.3301	54.5253
2025	10	25	19	40	0	12	0.1	0.9	26.99	94.7	6.3301	56.4127
2025	10	25	19	50	0	12	0.1	0.9	27.11	91.5	6.3301	56.8322
2025	10	25	20	0	0	12	0.1	0.9	26.97	94.3	6.3301	56.4128
2025	10	25	20	10	0	12	0.1	0.9	27.81	95.2	6.3301	58.0905
2025	10	25	20	20	0	12	0.1	0.9	27.05	93.6	6.3301	56.6226
2025	10	25	20	30	0	12	0.1	0.9	27.37	94	6.3301	57.2517
2025	10	25	20	40	0	12	0.1	0.9	27.85	93.3	6.3301	58.3003
2025	10	25	20	50	0	12	0.1	0.9	27.15	93.4	6.3301	56.8324
2025	10	25	21	0	0	12	0.1	0.9	26.63	92.6	6.3301	55.7838
2025	10	25	21	10	0	12	0.1	0.9	26.52	92.2	6.324	55.5183
2025	10	25	21	20	0	12	0.1	0.9	26.15	93.5	6.324	54.6803
2025	10	25	21	30	0	12	0.1	0.9	26.94	93.2	6.324	56.3564
2025	10	25	21	40	0	12	0.1	0.9	27.31	95.3	6.324	56.9849
2025	10	25	21	50	0	12	0.1	0.9	27.06	93.8	6.324	56.566
2025	10	25	22	0	0	12	0.1	0.9	26.73	92.8	6.324	55.9375
2025	10	25	22	10	0	12	0.1	0.9	26.79	94.7	6.324	55.9375
2025	10	25	22	20	0	12	0.1	0.9	26.04	93.3	6.324	54.471
2025	10	25	22	30	0	12	0.1	0.9	24.2	90.9	6.324	50.7
2025	10	25	22	40	0	12	0.1	0.9	26.79	94.7	6.324	55.9376
2025	10	25	22	50	0	12	0.1	0.9	27.47	94	6.324	57.4041
2025	10	25	23	0	0	12	0.1	0.9	25.81	91.3	6.324	54.0521
2025	10	25	23	10	0	12	0.1	0.9	27.39	94.6	6.324	57.1947
2025	10	25	23	20	0	12	0.1	0.9	26.33	92.8	6.324	55.0997
2025	10	25	23	30	0	12	0.1	0.9	26.54	93.2	6.324	55.5187
2025	10	25	23	40	0	12	0.1	0.9	26.87	94.1	6.324	56.1473
2025	10	25	23	50	0	12	0.1	0.9	26.35	93.7	6.324	55.0998
2025	10	26	0	0	0	12	0.1	0.9	26.53	92.8	6.324	55.5188

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	26	0	10	0	12	0.1	0.9	26.23	92.6	6.324	54.8903
2025	10	26	0	20	0	12	0.1	0.9	26.65	93.7	6.324	55.7284
2025	10	26	0	30	0	12	0.1	0.9	27.61	91.9	6.324	57.8234
2025	10	26	0	40	0	12	0.1	0.9	26.54	93.2	6.324	55.5189
2025	10	26	0	50	0	12	0.1	0.9	26.67	94.1	6.324	55.7284
2025	10	26	1	0	0	12	0.1	0.9	26.83	95.6	6.324	55.938
2025	10	26	1	10	0	12	0.1	0.9	27.2	94.9	6.324	56.776
2025	10	26	1	20	0	12	0.1	0.9	26.43	92.8	6.324	55.3095
2025	10	26	1	30	0	12	0.1	0.9	26.9	90.6	6.3179	56.3004
2025	10	26	1	40	0	12	0.1	0.9	25.72	92.2	6.324	53.843
2025	10	26	1	50	0	12	0.1	0.9	26.51	95.2	6.324	55.3096
2025	10	26	2	0	0	12	0.1	0.9	26.16	93.9	6.324	54.6811
2025	10	26	2	10	0	11.8	0.1	0.9	26.93	92.8	6.324	56.3572
2025	10	26	2	20	0	11.8	0.1	0.9	26.97	94	6.324	56.3572
2025	10	26	2	30	0	11.8	0.1	0.9	26.68	94.3	6.324	55.7287
2025	10	26	2	40	0	11.8	0.1	0.9	25.73	92.7	6.324	53.8431
2025	10	26	2	50	0	11.8	0.1	0.9	26.71	91.3	6.324	55.9382
2025	10	26	3	0	0	11.8	0.1	0.9	26.72	92.4	6.3301	55.9945
2025	10	26	3	10	0	11.8	0.1	0.9	26.18	94.4	6.3301	54.7362
2025	10	26	3	20	0	11.8	0.1	0.9	26.58	94.5	6.3362	55.6309
2025	10	26	3	30	0	11.8	0.1	0.9	26.99	94.7	6.3362	56.4706
2025	10	26	3	40	0	11.8	0.1	0.9	27.75	93.5	6.3362	58.1501
2025	10	26	3	50	0	11.8	0.1	0.9	26.58	94.5	6.3423	55.6868
2025	10	26	4	0	0	11.8	0.1	0.9	27.48	94.4	6.3362	57.5204
2025	10	26	4	10	0	11.8	0.1	0.9	26.64	93.2	6.3423	55.897
2025	10	26	4	20	0	11.8	0.1	0.9	26.29	94.8	6.3423	55.0564
2025	10	26	4	30	0	11.8	0.1	0.9	26.38	94.3	6.3423	55.2666
2025	10	26	4	40	0	11.8	0.1	0.9	26.45	93.5	6.3423	55.4767
2025	10	26	4	50	0	11.8	0.1	0.9	27.18	94.4	6.3423	56.9477
2025	10	26	5	0	0	11.8	0.1	0.9	26.97	94	6.3484	56.5841
2025	10	26	5	10	0	11.8	0.1	0.9	27.77	94.1	6.3423	58.2086
2025	10	26	5	20	0	11.8	0.1	0.9	26.07	94.2	6.3484	54.691
2025	10	26	5	30	0	11.8	0.1	0.9	26.48	94.5	6.3423	55.4768
2025	10	26	5	40	0	11.8	0.1	0.9	26.75	93.6	6.3423	56.1072
2025	10	26	5	50	0	11.8	0.1	0.9	27.17	94.2	6.3484	57.0049
2025	10	26	6	0	0	11.8	0.1	0.9	26.43	92.8	6.3484	55.5325
2025	10	26	6	10	0	11.8	0.1	0.9	26.27	94.1	6.3484	55.1118
2025	10	26	6	20	0	11.8	0.1	0.9	26.49	94.8	6.3484	55.5325
2025	10	26	6	30	0	11.8	0.1	0.9	26.08	94.6	6.3484	54.6911
2025	10	26	6	40	0	11.8	0.1	0.9	26.95	93.6	6.3484	56.5843
2025	10	26	6	50	0	11.8	0.1	0.9	26.29	94.8	6.3484	55.1118
2025	10	26	7	0	0	11.8	0.1	0.9	26.6	91.1	6.3484	55.9533
2025	10	26	7	10	0	11.8	0.1	0.9	27.08	94.4	6.3484	56.7947
2025	10	26	7	20	0	11.8	0.1	0.9	26.75	93.4	6.3484	56.1636
2025	10	26	7	30	0	11.8	0.1	0.9	27.43	92.7	6.3484	57.6361
2025	10	26	7	40	0	11.8	0.1	0.9	27.05	93.6	6.3484	56.7947
2025	10	26	7	50	0	11.8	0.1	0.9	27.83	95.6	6.3484	58.2672
2025	10	26	8	0	0	11.8	0.1	0.9	27.67	93.9	6.3484	58.0568

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	26	8	10	0	11.8	0.1	0.9	25.88	94.4	6.3484	54.2705
2025	10	26	8	20	0	11.8	0.1	0.9	27.59	94.6	6.3484	57.8465
2025	10	26	8	30	0	12	0.1	0.9	26.72	92.4	6.3484	56.1637
2025	10	26	8	40	0	12	0.1	0.9	26.45	93.5	6.3545	55.5883
2025	10	26	8	50	0	12.2	0.1	0.9	26.86	93.8	6.3545	56.4305
2025	10	26	9	0	0	12.4	0.1	0.9	26.88	94.5	6.3545	56.4305
2025	10	26	9	10	0	12.6	0.1	0.9	27.55	93.5	6.3545	57.9044
2025	10	26	9	20	0	12.8	0.1	0.9	27.14	93.2	6.3545	57.0622
2025	10	26	9	30	0	12.8	0.1	0.9	27.34	92.9	6.3545	57.4833
2025	10	26	9	40	0	12.8	0.1	0.9	27.73	92.7	6.3545	58.3255
2025	10	26	9	50	0	12.8	0.1	0.9	26.66	93.9	6.3545	56.0093
2025	10	26	10	0	0	12.8	0.1	0.9	26.21	91.7	6.3545	55.1671
2025	10	26	10	10	0	13	0.1	0.9	26.73	95.6	6.3545	56.0093
2025	10	26	10	20	0	13	0.1	0.9	27.31	95	6.3545	57.2726
2025	10	26	10	30	0	13.2	0.1	0.9	25.66	94	6.3545	53.9036
2025	10	26	10	40	0	13.4	0.1	0.9	28.16	93.7	6.3545	59.1676
2025	10	26	10	50	0	13.6	0.1	0.9	27.37	94	6.3606	57.5406
2025	10	26	11	0	0	13.8	0.1	0.9	28.66	93.6	6.3545	60.2203
2025	10	26	11	10	0	13.4	0.1	0.9	27.2	90.8	6.3545	57.2724
2025	10	26	11	20	0	13.4	0.1	0.9	27.44	92.9	6.3606	57.7512
2025	10	26	11	30	0	13.4	0.1	0.9	26.58	94.5	6.3606	55.8542
2025	10	26	11	40	0	14.2	0.1	0.9	26.04	96	6.3545	54.535
2025	10	26	11	50	0	14.2	0.1	0.9	26.4	95	6.3606	55.4326
2025	10	26	12	0	0	14.2	0.1	0.9	26.84	95.8	6.3545	56.2193
2025	10	26	12	10	0	14.2	0.1	0.9	26.63	92.8	6.3606	56.0648
2025	10	26	12	20	0	14.2	0.1	0.9	27.55	93.5	6.3606	57.9617
2025	10	26	12	30	0	14.2	0.1	0.9	26.85	93.6	6.3545	56.4297
2025	10	26	12	40	0	14.2	0.1	0.9	25.99	94.9	6.3606	54.5892
2025	10	26	12	50	0	14.2	0.1	0.9	27.8	95	6.3545	58.3247
2025	10	26	13	0	0	14.2	0.1	0.9	27.53	92.5	6.3545	57.9035
2025	10	26	13	10	0	14.2	0.1	0.9	27.25	93.6	6.3484	57.2145
2025	10	26	13	20	0	14.2	0.1	0.9	27.05	93.6	6.3545	56.8506
2025	10	26	13	30	0	14.2	0.1	0.9	26.18	94.6	6.3423	54.8456
2025	10	26	13	40	0	14.2	0.1	0.9	27.74	92.9	6.3545	58.3245
2025	10	26	13	50	0	14.2	0.1	0.9	28.06	93.7	6.3545	58.9561
2025	10	26	14	0	0	14.2	0.1	0.9	26.79	94.7	6.3484	56.1625
2025	10	26	14	10	0	14.2	0.1	0.9	27.23	92.5	6.3545	57.2716
2025	10	26	14	20	0	13.4	0.1	0.9	27.42	95.4	6.3484	57.4246
2025	10	26	14	30	0	13.6	0.1	0.9	27.15	93.4	6.3545	57.0609
2025	10	26	14	40	0	14.2	0.1	0.9	27.01	95.1	6.3484	56.5831
2025	10	26	14	50	0	14.2	0.1	0.9	27.32	95.5	6.3484	57.2141
2025	10	26	15	0	0	14.2	0.1	0.9	26.38	94.6	6.3484	55.321
2025	10	26	15	10	0	14.2	0.1	0.9	25.82	92	6.3484	54.2692
2025	10	26	15	20	0	14.2	0.1	0.9	27.43	92.5	6.3484	57.6347
2025	10	26	15	30	0	14.2	0.1	0.9	27.41	91.9	6.3423	57.5769
2025	10	26	15	40	0	14.2	0.1	0.9	26.95	93.6	6.3484	56.5829
2025	10	26	15	50	0	14.2	0.1	0.9	27.73	95.6	6.3423	57.9971
2025	10	26	16	0	0	14.2	0.1	0.9	26.16	96.4	6.3423	54.6349

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	26	16	10	0	14.2	0.1	0.9	27.92	92.3	6.3362	58.5687
2025	10	26	16	20	0	13.8	0.1	0.9	25.92	92	6.3423	54.4248
2025	10	26	16	30	0	13.8	0.1	0.9	26.88	94.5	6.3362	56.2595
2025	10	26	16	40	0	13.6	0.1	0.9	27.19	94.6	6.3362	56.8893
2025	10	26	16	50	0	13.6	0.1	0.9	26.08	94.6	6.3362	54.5801
2025	10	26	17	0	0	13.4	0.1	0.9	26.5	95	6.3362	55.4198
2025	10	26	17	10	0	13	0.1	0.9	26.93	92.6	6.3362	56.4694
2025	10	26	17	20	0	12.4	0.1	0.9	26.46	93.9	6.3362	55.4197
2025	10	26	17	30	0	12.2	0.1	0.9	28.05	93.5	6.3362	58.7785
2025	10	26	17	40	0	12.2	0.1	0.9	27.54	93.1	6.3301	57.671
2025	10	26	17	50	0	12.2	0.1	0.9	28.05	93.5	6.3362	58.7785
2025	10	26	18	0	0	12.2	0.1	0.9	26.88	94.5	6.3362	56.2594
2025	10	26	18	10	0	12.2	0.1	0.9	27.15	93.4	6.3362	56.8892
2025	10	26	18	20	0	12.2	0.1	0.9	27.36	93.8	6.3362	57.3091
2025	10	26	18	30	0	12.2	0.1	0.9	26.69	94.7	6.3362	55.8396
2025	10	26	18	40	0	12.2	0.1	0.9	27.55	93.5	6.3362	57.7289
2025	10	26	18	50	0	12.2	0.1	0.9	26.6	91.1	6.3362	55.8396
2025	10	26	19	0	0	12.2	0.1	0.9	28.24	93	6.3362	59.1984
2025	10	26	19	10	0	12.2	0.1	0.9	26.52	91.9	6.3362	55.6297
2025	10	26	19	20	0	12.2	0.1	0.9	26.92	91.9	6.3301	56.4127
2025	10	26	19	30	0	12.2	0.1	0.9	26.26	93.9	6.3362	55
2025	10	26	19	40	0	12.2	0.1	0.9	26.2	95	6.3301	54.7351
2025	10	26	19	50	0	12	0.1	0.9	26.2	91.1	6.3301	54.9448
2025	10	26	20	0	0	12	0.1	0.9	26.24	95.9	6.3301	54.7351
2025	10	26	20	10	0	12	0.1	0.9	26.18	94.6	6.3301	54.7352
2025	10	26	20	20	0	12	0.1	0.9	26.28	94.4	6.3301	54.9449
2025	10	26	20	30	0	12	0.1	0.9	27.89	94.5	6.324	58.2418
2025	10	26	20	40	0	12	0.1	0.9	26.11	91.5	6.324	54.6803
2025	10	26	20	50	0	12	0.1	0.9	27.49	94.6	6.324	57.4038
2025	10	26	21	0	0	12	0.1	0.9	26.64	93	6.324	55.7278
2025	10	26	21	10	0	12	0.1	0.9	26.57	94.1	6.324	55.5183
2025	10	26	21	20	0	12	0.1	0.9	27.85	93.3	6.324	58.2419
2025	10	26	21	30	0	12	0.1	0.9	26.42	92.2	6.324	55.3089
2025	10	26	21	40	0	12	0.1	0.9	27.48	94.4	6.324	57.404
2025	10	26	21	50	0	12	0.1	0.9	26.88	94.5	6.324	56.147
2025	10	26	22	0	0	12	0.1	0.9	26.32	95.5	6.3179	54.8348
2025	10	26	22	10	0	12	0.1	0.9	27.11	91.9	6.3179	56.7184
2025	10	26	22	20	0	12	0.1	0.9	26.73	92.6	6.3179	55.8813
2025	10	26	22	30	0	12	0.1	0.9	26.06	94	6.3179	54.4163
2025	10	26	22	40	0	12	0.1	0.9	25.93	95.8	6.3179	53.9977
2025	10	26	22	50	0	12	0.1	0.9	26.76	93.9	6.3179	55.8814
2025	10	26	23	0	0	12	0.1	0.9	27.15	93.6	6.3179	56.7186
2025	10	26	23	10	0	12	0.1	0.9	26.51	91.5	6.3179	55.4628
2025	10	26	23	20	0	12	0.1	0.9	25.83	95.8	6.3179	53.7885
2025	10	26	23	30	0	12	0.1	0.9	26.14	93.1	6.3179	54.6257
2025	10	26	23	40	0	12	0.1	0.9	26.73	92.8	6.3179	55.8815
2025	10	26	23	50	0	12	0.1	0.9	27.24	93.2	6.3179	56.928
2025	10	27	0	0	0	12	0.1	0.9	26.74	93	6.3179	55.8816

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	27	0	10	0	12	0.1	0.9	27.22	92.3	6.3179	56.9281
2025	10	27	0	20	0	12	0.1	0.9	26.73	92.8	6.3179	55.8816
2025	10	27	0	30	0	12	0.1	0.9	27.22	95.3	6.3179	56.7188
2025	10	27	0	40	0	12	0.1	0.9	27.44	92.9	6.3118	57.289
2025	10	27	0	50	0	12	0.1	0.9	26.33	95.7	6.3118	54.78
2025	10	27	1	0	0	12	0.1	0.9	26.42	92.4	6.3118	55.1982
2025	10	27	1	10	0	12	0.1	0.9	26.32	92.2	6.3179	55.0446
2025	10	27	1	20	0	12	0.1	0.9	27.45	93.3	6.3118	57.2891
2025	10	27	1	30	0	12	0.1	0.9	24.82	92.5	6.3118	51.853
2025	10	27	1	40	0	12	0.1	0.9	26.33	92.6	6.3118	54.9893
2025	10	27	1	50	0	12	0.1	0.9	26.44	93	6.3118	55.1984
2025	10	27	2	0	0	12	0.1	0.9	26.91	91.7	6.3118	56.2438
2025	10	27	2	10	0	12	0.1	0.9	27.93	92.5	6.3118	58.3347
2025	10	27	2	20	0	12	0.1	0.9	26.73	95.6	6.3118	55.6166
2025	10	27	2	30	0	11.8	0.1	0.9	26.28	96.8	6.3118	54.5712
2025	10	27	2	40	0	11.8	0.1	0.9	26.71	91.3	6.3118	55.8258
2025	10	27	2	50	0	11.8	0.1	0.9	27.76	96.2	6.3118	57.7076
2025	10	27	3	0	0	11.8	0.1	0.9	25.73	92.7	6.3118	53.735
2025	10	27	3	10	0	11.8	0.1	0.9	26.41	91.7	6.3118	55.1986
2025	10	27	3	20	0	11.8	0.1	0.9	27.16	93.8	6.3118	56.6622
2025	10	27	3	30	0	11.8	0.1	0.9	26.02	92.2	6.3118	54.3623
2025	10	27	3	40	0	11.8	0.1	0.9	27.16	93.8	6.3118	56.6623
2025	10	27	3	50	0	11.8	0.1	0.9	26.18	94.6	6.3118	54.5715
2025	10	27	4	0	0	11.8	0.1	0.9	27.35	93.6	6.3118	57.0805
2025	10	27	4	10	0	11.8	0.1	0.9	25.99	94.9	6.3118	54.1533
2025	10	27	4	20	0	11.8	0.1	0.9	27.55	93.5	6.3118	57.4987
2025	10	27	4	30	0	11.8	0.1	0.9	27.35	96.1	6.3118	56.8715
2025	10	27	4	40	0	11.8	0.1	0.9	26.42	95.4	6.3118	54.9897
2025	10	27	4	50	0	11.8	0.1	0.9	26.65	93.7	6.3118	55.617
2025	10	27	5	0	0	11.8	0.1	0.9	26.79	94.7	6.3118	55.8261
2025	10	27	5	10	0	11.8	0.1	0.9	26.7	94.9	6.3118	55.6171
2025	10	27	5	20	0	11.8	0.1	0.9	25.52	92.2	6.3118	53.3171
2025	10	27	5	30	0	11.8	0.1	0.9	27.08	94.4	6.3118	56.4535
2025	10	27	5	40	0	11.8	0.1	0.9	26.65	93.7	6.3118	55.6171
2025	10	27	5	50	0	11.8	0.1	0.9	26.94	93.2	6.3118	56.2444
2025	10	27	6	0	0	11.8	0.1	0.9	25.68	94.5	6.3118	53.5263
2025	10	27	6	10	0	11.8	0.1	0.9	26.45	93.7	6.3118	55.199
2025	10	27	6	20	0	11.8	0.1	0.9	26.38	94.3	6.3118	54.99
2025	10	27	6	30	0	11.8	0.1	0.9	26.85	93.6	6.3118	56.0354
2025	10	27	6	40	0	11.8	0.1	0.9	27.82	95.4	6.3118	57.9172
2025	10	27	6	50	0	11.8	0.1	0.9	27.43	95.6	6.3179	57.1384
2025	10	27	7	0	0	11.8	0.1	0.9	26.54	93	6.3118	55.4082
2025	10	27	7	10	0	11.8	0.1	0.9	26.28	94.6	6.3179	54.8361
2025	10	27	7	20	0	11.8	0.1	0.9	26.35	93.5	6.3179	55.0455
2025	10	27	7	30	0	11.8	0.1	0.9	26.38	94.6	6.3179	55.0455
2025	10	27	7	40	0	11.8	0.1	0.9	27.96	93.7	6.3179	58.3943
2025	10	27	7	50	0	11.8	0.1	0.9	27.57	94	6.3179	57.5571
2025	10	27	8	0	0	11.8	0.1	0.9	26.25	93.5	6.324	54.8914

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	27	8	10	0	12.4	0.1	0.9	26.26	93.9	6.324	54.8914
2025	10	27	8	20	0	12.8	0.1	0.9	26.76	93.9	6.324	55.939
2025	10	27	8	30	0	12.8	0.1	0.9	26.53	92.8	6.324	55.52
2025	10	27	8	40	0	13	0.1	0.9	26.97	94.3	6.324	56.358
2025	10	27	8	50	0	13	0.1	0.9	26.34	93	6.324	55.101
2025	10	27	9	0	0	13	0.1	0.9	26.33	92.8	6.3301	55.1564
2025	10	27	9	10	0	13	0.1	0.9	27.04	93	6.3301	56.6244
2025	10	27	9	20	0	13	0.1	0.9	26.85	93.6	6.3301	56.2049
2025	10	27	9	30	0	13.2	0.1	0.9	25.82	92	6.3301	54.1077
2025	10	27	9	40	0	13.2	0.1	0.9	26.39	94.8	6.3301	55.1563
2025	10	27	9	50	0	13.2	0.1	0.9	27.15	93.6	6.3301	56.834
2025	10	27	10	0	0	13.2	0.1	0.9	26.02	95.5	6.3301	54.3173
2025	10	27	10	10	0	13.6	0.1	0.9	26.96	93.8	6.3301	56.4145
2025	10	27	10	20	0	13.4	0.1	0.9	27.68	94.4	6.3301	57.8825
2025	10	27	10	30	0	13.6	0.1	0.9	26.86	96.2	6.324	55.9387
2025	10	27	10	40	0	14.2	0.1	0.9	26.63	92.8	6.324	55.7292
2025	10	27	10	50	0	14.2	0.1	0.9	26.85	93.6	6.324	56.1482
2025	10	27	11	0	0	14.2	0.1	0.9	27	94.9	6.324	56.3576
2025	10	27	11	10	0	14.2	0.1	0.9	25.95	93.5	6.324	54.2625
2025	10	27	11	20	0	13.6	0.1	0.9	26.52	95.4	6.3179	55.2543
2025	10	27	11	30	0	14.2	0.1	0.9	26.77	94.1	6.324	55.9384
2025	10	27	11	40	0	14.2	0.1	0.9	27.4	94.8	6.3179	57.1379
2025	10	27	11	50	0	14.2	0.1	0.9	26.55	93.7	6.3179	55.4635
2025	10	27	12	0	0	14.2	0.1	0.9	26.38	94.3	6.3179	55.0448
2025	10	27	12	10	0	14.2	0.1	0.9	26.72	95.4	6.3179	55.6726
2025	10	27	12	20	0	14.2	0.1	0.9	26.87	94.3	6.3179	56.0912
2025	10	27	12	30	0	14.2	0.1	0.9	25.89	94.7	6.3179	53.9982
2025	10	27	12	40	0	14.2	0.1	0.9	26.38	94.3	6.3179	55.0446
2025	10	27	12	50	0	14.2	0.1	0.9	26.16	93.7	6.3179	54.6259
2025	10	27	13	0	0	14.2	0.1	0.9	26.51	95.2	6.3179	55.2538
2025	10	27	13	10	0	14.2	0.1	0.9	27.25	93.4	6.3179	56.9281
2025	10	27	13	20	0	14	0.1	0.9	26.79	94.7	6.3179	55.8815
2025	10	27	13	30	0	14.2	0.1	0.9	27.07	94.2	6.3179	56.5094
2025	10	27	13	40	0	14.2	0.1	0.9	25.66	93.8	6.3179	53.5792
2025	10	27	13	50	0	14.2	0.1	0.9	27.25	96.1	6.3179	56.7186
2025	10	27	14	0	0	14.2	0.1	0.9	26.77	94.3	6.3179	55.8813
2025	10	27	14	10	0	14.2	0.1	0.9	26.43	92.6	6.3179	55.2534
2025	10	27	14	20	0	14.2	0.1	0.9	26.29	94.8	6.3179	54.8348
2025	10	27	14	30	0	14.2	0.1	0.9	26.56	93.9	6.3179	55.4626
2025	10	27	14	40	0	14.2	0.1	0.9	26.93	92.8	6.3179	56.2998
2025	10	27	14	50	0	14.2	0.1	0.9	27.52	95.4	6.3179	57.3462
2025	10	27	15	0	0	14.2	0.1	0.9	26.67	94.1	6.3179	55.6718
2025	10	27	15	10	0	14.2	0.1	0.9	27.58	94.4	6.3179	57.5554
2025	10	27	15	20	0	14.2	0.1	0.9	26.16	93.7	6.3179	54.6253
2025	10	27	15	30	0	14.2	0.1	0.9	26.45	93.7	6.3179	55.2531
2025	10	27	15	40	0	14	0.1	0.9	26.76	93.9	6.3179	55.881
2025	10	27	15	50	0	14	0.1	0.9	27.65	93.5	6.3179	57.7646
2025	10	27	16	0	0	14	0.1	0.9	27.15	93.6	6.3179	56.7181

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	27	16	10	0	13.8	0.1	0.9	25.8	90.9	6.324	54.0516
2025	10	27	16	20	0	13.6	0.1	0.9	27.34	95.9	6.324	56.9847
2025	10	27	16	30	0	13.4	0.1	0.9	26.65	93.7	6.324	55.7276
2025	10	27	16	40	0	13.4	0.1	0.9	26.67	94.1	6.3179	55.6716
2025	10	27	16	50	0	13.4	0.1	0.9	25.96	93.8	6.3179	54.2065
2025	10	27	17	0	0	13.2	0.1	0.9	26	95.1	6.3179	54.2065
2025	10	27	17	10	0	13.2	0.1	0.9	27.83	92.7	6.324	58.2416
2025	10	27	17	20	0	12.2	0.1	0.9	27.22	95.3	6.324	56.7751
2025	10	27	17	30	0	12.2	0.1	0.9	27.45	93.6	6.324	57.4036
2025	10	27	17	40	0	12.2	0.1	0.9	26.76	93.9	6.324	55.9371
2025	10	27	17	50	0	12.2	0.1	0.9	26.16	93.9	6.324	54.68
2025	10	27	18	0	0	12.2	0.1	0.9	25.73	92.9	6.324	53.842
2025	10	27	18	10	0	12.2	0.1	0.9	27.97	94.1	6.324	58.4511
2025	10	27	18	20	0	12.2	0.1	0.9	27.51	91.9	6.324	57.6131
2025	10	27	18	30	0	12.2	0.1	0.9	27.05	93.6	6.324	56.5656
2025	10	27	18	40	0	12.2	0.1	0.9	26.22	92	6.3179	54.8344
2025	10	27	18	50	0	12.2	0.1	0.9	26.7	94.9	6.324	55.7276
2025	10	27	19	0	0	12.2	0.1	0.9	26.89	94.7	6.3179	56.0902
2025	10	27	19	10	0	12	0.1	0.9	27.61	91.2	6.3179	57.7645
2025	10	27	19	20	0	12	0.1	0.9	25.96	94	6.3179	54.2066
2025	10	27	19	30	0	12	0.1	0.9	26.94	93.2	6.3179	56.2996
2025	10	27	19	40	0	12	0.1	0.9	25.71	91.8	6.3179	53.7881
2025	10	27	19	50	0	12	0.1	0.9	27.08	94.4	6.3179	56.5089
2025	10	27	20	0	0	12	0.1	0.9	26.24	93.3	6.3179	54.8346
2025	10	27	20	10	0	12	0.1	0.9	27.83	92.7	6.3179	58.1833
2025	10	27	20	20	0	12	0.1	0.9	27.15	93.6	6.3179	56.7183
2025	10	27	20	30	0	12	0.1	0.9	27.41	91.9	6.3179	57.3462
2025	10	27	20	40	0	12	0.1	0.9	26.65	93.4	6.3118	55.6159
2025	10	27	20	50	0	12	0.1	0.9	27.15	93.4	6.3118	56.6613
2025	10	27	21	0	0	12	0.1	0.9	27.15	93.6	6.3118	56.6614
2025	10	27	21	10	0	12	0.1	0.9	26.16	93.7	6.3118	54.5706
2025	10	27	21	20	0	12	0.1	0.9	25.78	94.4	6.3118	53.7343
2025	10	27	21	30	0	12	0.1	0.9	26.45	93.5	6.3118	55.1979
2025	10	27	21	40	0	12	0.1	0.9	26.74	93.2	6.3118	55.8252
2025	10	27	21	50	0	12	0.1	0.9	27.12	92.3	6.3118	56.6616
2025	10	27	22	0	0	12	0.1	0.9	26.16	93.7	6.3118	54.5708
2025	10	27	22	10	0	12	0.1	0.9	27.27	94	6.3118	56.8707
2025	10	27	22	20	0	12	0.1	0.9	26.32	92	6.3118	54.989
2025	10	27	22	30	0	12	0.1	0.9	27.05	93.6	6.3057	56.3957
2025	10	27	22	40	0	12	0.1	0.9	27.03	92.5	6.3118	56.4526
2025	10	27	22	50	0	12	0.1	0.9	26.73	92.8	6.3118	55.8254
2025	10	27	23	0	0	12	0.1	0.9	26.62	95.4	6.3057	55.3515
2025	10	27	23	10	0	12	0.1	0.9	26.73	95.6	6.3057	55.5604
2025	10	27	23	20	0	12	0.1	0.9	27.19	94.6	6.3057	56.6048
2025	10	27	23	30	0	12	0.1	0.9	26.45	93.5	6.3057	55.1427
2025	10	27	23	40	0	12	0.1	0.9	26.55	93.7	6.3057	55.3516
2025	10	27	23	50	0	12	0.1	0.9	27.25	93.6	6.3057	56.8138
2025	10	28	0	0	0	12	0.1	0.9	26.72	95.4	6.3057	55.5605

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	28	0	10	0	12	0.1	0.9	25.54	93.4	6.3057	53.2629
2025	10	28	0	20	0	12	0.1	0.9	26.21	95.3	6.3057	54.5162
2025	10	28	0	30	0	12	0.1	0.9	25.83	92.9	6.3057	53.8896
2025	10	28	0	40	0	12	0.1	0.9	26.62	92.4	6.3057	55.5606
2025	10	28	0	50	0	12	0.1	0.9	26.52	91.9	6.3057	55.3518
2025	10	28	1	0	0	12	0.1	0.9	26.62	92.2	6.3057	55.5607
2025	10	28	1	10	0	12	0.1	0.9	26.45	93.7	6.3057	55.143
2025	10	28	1	20	0	12	0.1	0.9	26.11	91.8	6.3057	54.5164
2025	10	28	1	30	0	12	0.1	0.9	25.97	94.2	6.3057	54.0987
2025	10	28	1	40	0	11.8	0.1	0.9	27.91	95.1	6.3057	58.0673
2025	10	28	1	50	0	11.8	0.1	0.9	26.08	94.6	6.3057	54.3076
2025	10	28	2	0	0	11.8	0.1	0.9	26.63	92.8	6.3057	55.5609
2025	10	28	2	10	0	11.8	0.1	0.9	25.56	94	6.3057	53.2632
2025	10	28	2	20	0	11.8	0.1	0.9	27.55	93.3	6.3057	57.4408
2025	10	28	2	30	0	11.8	0.1	0.9	26.95	93.4	6.3057	56.1875
2025	10	28	2	40	0	11.8	0.1	0.9	27.18	94.4	6.3057	56.6053
2025	10	28	2	50	0	11.8	0.1	0.9	27.41	95.2	6.3057	57.0231
2025	10	28	3	0	0	11.8	0.1	0.9	26.6	90.9	6.2996	55.5049
2025	10	28	3	10	0	11.8	0.1	0.9	26.91	95.1	6.3057	55.9787
2025	10	28	3	20	0	11.8	0.1	0.9	26.44	93.3	6.3057	55.1432
2025	10	28	3	30	0	11.8	0.1	0.9	25.66	94	6.3057	53.4723
2025	10	28	3	40	0	11.8	0.1	0.9	28.29	94.7	6.3057	58.903
2025	10	28	3	50	0	11.8	0.1	0.9	27.76	96.2	6.3057	57.6498
2025	10	28	4	0	0	11.8	0.1	0.9	27.08	94.4	6.3057	56.3966
2025	10	28	4	10	0	11.8	0.1	0.9	25.59	94.9	6.3057	53.2634
2025	10	28	4	20	0	11.8	0.1	0.9	26.93	95.5	6.3057	55.9788
2025	10	28	4	30	0	11.8	0.1	0.9	26.21	91.3	6.3057	54.7256
2025	10	28	4	40	0	11.8	0.1	0.9	26.03	92.9	6.3057	54.3079
2025	10	28	4	50	0	11.8	0.1	0.9	26.32	92	6.3057	54.9345
2025	10	28	5	0	0	11.8	0.1	0.9	27.26	93.8	6.3057	56.8144
2025	10	28	5	10	0	11.8	0.1	0.9	27.2	91.1	6.3057	56.8144
2025	10	28	5	20	0	11.8	0.1	0.9	26.62	92.2	6.3057	55.5612
2025	10	28	5	30	0	11.8	0.1	0.9	26.41	95.2	6.3057	54.9346
2025	10	28	5	40	0	11.8	0.1	0.9	27.53	92.7	6.3057	57.4411
2025	10	28	5	50	0	11.8	0.1	0.9	27.25	93.4	6.3057	56.8145
2025	10	28	6	0	0	11.8	0.1	0.9	27.63	92.5	6.3057	57.65
2025	10	28	6	10	0	11.8	0.1	0.9	27.07	94	6.3057	56.3968
2025	10	28	6	20	0	11.8	0.1	0.9	27.01	91.3	6.3057	56.3968
2025	10	28	6	30	0	11.8	0.1	0.9	25.5	90.9	6.3057	53.2636
2025	10	28	6	40	0	11.8	0.1	0.9	25.59	94.7	6.3057	53.2637
2025	10	28	6	50	0	11.8	0.1	0.9	27.03	95.5	6.3057	56.188
2025	10	28	7	0	0	11.8	0.1	0.9	27.58	94.4	6.3057	57.4412
2025	10	28	7	10	0	11.6	0.1	0.9	26.57	94.1	6.3057	55.3525
2025	10	28	7	20	0	11.6	0.1	0.9	26.93	92.6	6.3057	56.188
2025	10	28	7	30	0	11.6	0.1	0.9	25.81	91.8	6.3057	53.8904
2025	10	28	7	40	0	11.6	0.1	0.9	26.35	93.5	6.3057	54.9348
2025	10	28	7	50	0	11.6	0.1	0.9	26.26	93.7	6.3057	54.7259
2025	10	28	8	0	0	11.8	0.1	0.9	25.72	92	6.3057	53.6815

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	28	8	10	0	12.2	0.1	0.9	27.04	93	6.3057	56.3969
2025	10	28	8	20	0	12.6	0.1	0.9	25.74	93.1	6.3057	53.6815
2025	10	28	8	30	0	12.8	0.1	0.9	26.45	93.7	6.3057	55.1437
2025	10	28	8	40	0	13	0.1	0.9	26.68	94.3	6.3057	55.5615
2025	10	28	8	50	0	13	0.1	0.9	27.13	95.7	6.3057	56.3969
2025	10	28	9	0	0	13	0.1	0.9	27.77	94.1	6.3057	57.8591
2025	10	28	9	10	0	13	0.1	0.9	26.72	92.1	6.3057	55.7703
2025	10	28	9	20	0	13.4	0.1	0.9	25.73	92.9	6.3057	53.6815
2025	10	28	9	30	0	13.4	0.1	0.9	26.82	95.3	6.3057	55.7703
2025	10	28	9	40	0	13.4	0.1	0.9	26.05	93.5	6.3057	54.3081
2025	10	28	9	50	0	13.4	0.1	0.9	26.27	94.1	6.3057	54.7258
2025	10	28	10	0	0	13.4	0.1	0.9	26.75	93.6	6.3057	55.7702
2025	10	28	10	10	0	13.4	0.1	0.9	26.73	92.8	6.3057	55.7702
2025	10	28	10	20	0	14	0.1	0.9	26.46	93.9	6.3118	55.1991
2025	10	28	10	30	0	14.2	0.1	0.9	26.64	93.2	6.3057	55.5612
2025	10	28	10	40	0	14.2	0.1	0.9	25.64	93.4	6.3118	53.5263
2025	10	28	10	50	0	14.2	0.1	0.9	26.25	93.5	6.3118	54.7808
2025	10	28	11	0	0	14.2	0.1	0.9	27.07	94	6.3118	56.4535
2025	10	28	11	10	0	14.2	0.1	0.9	26.36	93.9	6.3118	54.9898
2025	10	28	11	20	0	14.2	0.1	0.9	26.84	93.2	6.3118	56.0352
2025	10	28	11	30	0	14.2	0.1	0.9	26.54	93	6.3118	55.4079
2025	10	28	11	40	0	14.2	0.1	0.9	27.55	93.3	6.3118	57.4987
2025	10	28	11	50	0	14.2	0.1	0.9	26.14	93.3	6.3118	54.5714
2025	10	28	12	0	0	14.2	0.1	0.9	25.82	92.2	6.3118	53.9441
2025	10	28	12	10	0	14.2	0.1	0.9	26.7	94.9	6.3118	55.6168
2025	10	28	12	20	0	14.2	0.1	0.9	26.29	94.8	6.3118	54.7804
2025	10	28	12	30	0	14.2	0.1	0.9	27.19	96.8	6.3118	56.453
2025	10	28	12	40	0	14.2	0.1	0.9	26.53	92.6	6.3118	55.4075
2025	10	28	12	50	0	14.2	0.1	0.9	27.12	95.3	6.3118	56.4529
2025	10	28	13	0	0	14.2	0.1	0.9	26.77	96.4	6.3118	55.6165
2025	10	28	13	10	0	14.2	0.1	0.9	26.32	95.5	6.3179	54.8353
2025	10	28	13	20	0	14.2	0.1	0.9	28	94.9	6.3179	58.3932
2025	10	28	13	30	0	14.2	0.1	0.9	27.7	94.8	6.3179	57.7653
2025	10	28	13	40	0	14.2	0.1	0.9	26.84	93.2	6.3179	56.0909
2025	10	28	13	50	0	14.2	0.1	0.9	26.81	91.5	6.3179	56.0909
2025	10	28	14	0	0	14.2	0.1	0.9	26.33	92.8	6.3179	55.0443
2025	10	28	14	10	0	14.2	0.1	0.9	27.99	94.5	6.3179	58.393
2025	10	28	14	20	0	14.2	0.1	0.9	26.49	94.8	6.3179	55.2535
2025	10	28	14	30	0	14.2	0.1	0.9	26.42	92	6.3179	55.2535
2025	10	28	14	40	0	14.2	0.1	0.9	26.96	96.2	6.3179	56.0906
2025	10	28	14	50	0	14.2	0.1	0.9	26.92	91.9	6.3179	56.2999
2025	10	28	15	0	0	14.2	0.1	0.9	27.35	93.4	6.3179	57.137
2025	10	28	15	10	0	14.2	0.1	0.9	26.87	94.1	6.3179	56.0905
2025	10	28	15	20	0	14.2	0.1	0.9	26.94	93	6.3179	56.2998
2025	10	28	15	30	0	14.2	0.1	0.9	26.26	93.7	6.3179	54.8347
2025	10	28	15	40	0	14	0.1	0.9	26.37	94.1	6.3179	55.044
2025	10	28	15	50	0	14	0.1	0.9	26.94	93	6.3179	56.2997
2025	10	28	16	0	0	14	0.1	0.9	27.65	93.3	6.3179	57.7648

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	28	16	10	0	13.8	0.1	0.9	27.32	92.3	6.3179	57.1369
2025	10	28	16	20	0	13.2	0.1	0.9	27.44	93.1	6.3179	57.3461
2025	10	28	16	30	0	13.2	0.1	0.9	26.85	93.4	6.3179	56.0904
2025	10	28	16	40	0	13.2	0.1	0.9	26.53	92.8	6.3179	55.4625
2025	10	28	16	50	0	13.2	0.1	0.9	26.75	93.6	6.3179	55.8811
2025	10	28	17	0	0	13.2	0.1	0.9	27.22	95.5	6.3179	56.7182
2025	10	28	17	10	0	13	0.1	0.9	27.13	92.7	6.3179	56.7182
2025	10	28	17	20	0	12.2	0.1	0.9	26.96	93.8	6.3179	56.2996
2025	10	28	17	30	0	12.2	0.1	0.9	26.65	93.7	6.3179	55.6717
2025	10	28	17	40	0	12.2	0.1	0.9	25.82	92.4	6.3179	53.9974
2025	10	28	17	50	0	12.2	0.1	0.9	25.91	91.5	6.3179	54.2067
2025	10	28	18	0	0	12	0.1	0.9	26.94	93.2	6.3179	56.2996
2025	10	28	18	10	0	11.4	0.1	0.9	25.83	92.9	6.3179	53.9974
2025	10	28	18	20	0	12	0.1	0.9	26.02	92.4	6.3179	54.416
2025	10	28	18	30	0	11.6	0.1	0.9	27.01	91.9	6.3179	56.509
2025	10	28	18	40	0	11.6	0.1	0.9	26.07	94.2	6.3179	54.4161
2025	10	28	18	50	0	11.4	0.1	0.9	26.99	94.7	6.3179	56.2997
2025	10	28	19	0	0	11.4	0.1	0.9	27.8	94.7	6.3179	57.9741
2025	10	28	19	10	0	11.4	0.1	0.9	27.27	94.2	6.3179	56.9276
2025	10	28	19	20	0	12	0.1	0.9	25.55	93.6	6.3179	53.3697
2025	10	28	19	30	0	12	0.1	0.9	27.22	92.1	6.3179	56.9277
2025	10	28	19	40	0	12	0.1	0.9	26.44	93.3	6.3179	55.2534
2025	10	28	19	50	0	12	0.1	0.9	26.34	93	6.3179	55.0441
2025	10	28	20	0	0	12	0.1	0.9	25.52	92	6.3179	53.3698
2025	10	28	20	10	0	12	0.1	0.9	26.53	95.6	6.3118	55.1979
2025	10	28	20	20	0	12	0.1	0.9	26.18	94.6	6.3118	54.5707
2025	10	28	20	30	0	12	0.1	0.9	27.75	93.5	6.3118	57.916
2025	10	28	20	40	0	12	0.1	0.9	26.7	91.1	6.3118	55.8252
2025	10	28	20	50	0	12	0.1	0.9	27.99	94.5	6.3118	58.3342
2025	10	28	21	0	0	12	0.1	0.9	26.09	94.8	6.3118	54.3617
2025	10	28	21	10	0	12	0.1	0.9	25.8	90.4	6.3118	53.9436
2025	10	28	21	20	0	12	0.1	0.9	26.36	93.9	6.3118	54.989
2025	10	28	21	30	0	12	0.1	0.9	27.1	94.9	6.3118	56.4526
2025	10	28	21	40	0	12	0.1	0.9	26.29	94.8	6.3118	54.78
2025	10	28	21	50	0	12	0.1	0.9	26.65	93.4	6.3118	55.6164
2025	10	28	22	0	0	12	0.1	0.9	25.69	94.9	6.3118	53.5255
2025	10	28	22	10	0	12	0.1	0.9	25.96	93.8	6.3118	54.1528
2025	10	28	22	20	0	12	0.1	0.9	25.59	94.9	6.3118	53.3165
2025	10	28	22	30	0	12	0.1	0.9	26.74	95.8	6.3118	55.6165
2025	10	28	22	40	0	12	0.1	0.9	25.97	94.2	6.3118	54.1529
2025	10	28	22	50	0	12	0.1	0.9	26.86	93.8	6.3057	55.9783
2025	10	28	23	0	0	11.6	0.1	0.9	26.7	94.9	6.3057	55.5606
2025	10	28	23	10	0	11.4	0.1	0.9	26.75	93.4	6.3118	55.8257
2025	10	28	23	20	0	12	0.1	0.9	25.73	92.9	6.3057	53.6808
2025	10	28	23	30	0	12	0.1	0.9	26.6	90.9	6.3118	55.6167
2025	10	28	23	40	0	12	0.1	0.9	26.17	94.2	6.3057	54.5163
2025	10	28	23	50	0	12	0.1	0.9	26.36	93.9	6.3057	54.9341
2025	10	29	0	0	0	12	0.1	0.9	26.53	92.6	6.3057	55.3519

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	29	0	10	0	12	0.1	0.9	27.05	93.4	6.3057	56.3963
2025	10	29	0	20	0	12	0.1	0.9	26.33	92.8	6.3057	54.9342
2025	10	29	0	30	0	12	0.1	0.9	27.79	94.5	6.3057	57.8585
2025	10	29	0	40	0	12	0.1	0.9	25.42	92	6.3057	53.0544
2025	10	29	0	50	0	12	0.1	0.9	27.18	94.4	6.3057	56.6053
2025	10	29	1	0	0	12	0.1	0.9	26.75	93.4	6.3057	55.7698
2025	10	29	1	10	0	12	0.1	0.9	27.43	92.7	6.3057	57.232
2025	10	29	1	20	0	12	0.1	0.9	27.05	93.6	6.3057	56.3965
2025	10	29	1	30	0	11.8	0.1	0.9	26.77	96.4	6.3057	55.5611
2025	10	29	1	40	0	11.8	0.1	0.9	27.28	94.4	6.3057	56.8144
2025	10	29	1	50	0	11.8	0.1	0.9	27.68	94.4	6.3057	57.6499
2025	10	29	2	0	0	11.8	0.1	0.9	26.16	93.9	6.3057	54.5168
2025	10	29	2	10	0	11.8	0.1	0.9	26.85	93.6	6.3057	55.9789
2025	10	29	2	20	0	11.8	0.1	0.9	27.07	94	6.3057	56.3967
2025	10	29	2	30	0	11.8	0.1	0.9	26.68	94.5	6.3057	55.5612
2025	10	29	2	40	0	11.8	0.1	0.9	26.42	92	6.3057	55.1435
2025	10	29	2	50	0	11.8	0.1	0.9	26.35	93.5	6.3057	54.9346
2025	10	29	3	0	0	11.8	0.1	0.9	26.97	94.3	6.3057	56.1879
2025	10	29	3	10	0	11.8	0.1	0.9	25.93	92.7	6.3057	54.0992
2025	10	29	3	20	0	11.8	0.1	0.9	27.53	92.7	6.3057	57.4412
2025	10	29	3	30	0	11.8	0.1	0.9	26.05	93.5	6.3057	54.3081
2025	10	29	3	40	0	11.8	0.1	0.9	27.05	93.6	6.3057	56.3969
2025	10	29	3	50	0	11.8	0.1	0.9	25.98	94.4	6.3057	54.0993
2025	10	29	4	0	0	11.8	0.1	0.9	26.85	93.6	6.3057	55.9792
2025	10	29	4	10	0	11.8	0.1	0.9	27.5	94.8	6.3057	57.2325
2025	10	29	4	20	0	11.2	0.1	0.9	26.85	96	6.3057	55.7703
2025	10	29	4	30	0	11.2	0.1	0.9	26.74	93.2	6.3057	55.7704
2025	10	29	4	40	0	11.2	0.1	0.9	26.5	95	6.3057	55.1437
2025	10	29	4	50	0	11.2	0.1	0.9	26.07	94.2	6.3057	54.3082
2025	10	29	5	0	0	11.2	0.1	0.9	26.85	93.6	6.3057	55.9793
2025	10	29	5	10	0	11.2	0.1	0.9	27.21	95.1	6.3057	56.6059
2025	10	29	5	20	0	11.8	0.1	0.9	25.96	93.8	6.3057	54.0994
2025	10	29	5	30	0	11.8	0.1	0.9	25.93	92.9	6.3057	54.0994
2025	10	29	5	40	0	11.8	0.1	0.9	26.14	93.3	6.3057	54.5172
2025	10	29	5	50	0	11.8	0.1	0.9	27.02	95.3	6.3057	56.1882
2025	10	29	6	0	0	11.8	0.1	0.9	28.35	95.9	6.3118	58.9631
2025	10	29	6	10	0	11.8	0.1	0.9	26.95	93.4	6.3118	56.2449
2025	10	29	6	20	0	11.8	0.1	0.9	25.75	93.6	6.3118	53.7359
2025	10	29	6	30	0	11.8	0.1	0.9	27.43	92.7	6.3118	57.2904
2025	10	29	6	40	0	11.8	0.1	0.9	27.21	95.1	6.3118	56.6632
2025	10	29	6	50	0	11.8	0.1	0.9	25.87	96.7	6.3118	53.736
2025	10	29	7	0	0	11.8	0.1	0.9	26.23	92.6	6.3179	54.8366
2025	10	29	7	10	0	11.8	0.1	0.9	26.58	94.5	6.3179	55.4645
2025	10	29	7	20	0	11.8	0.1	0.9	26.82	95.3	6.3179	55.8831
2025	10	29	7	30	0	11.8	0.1	0.9	26.85	93.4	6.324	56.1489
2025	10	29	7	40	0	11.8	0.1	0.9	26.16	93.7	6.324	54.6824
2025	10	29	7	50	0	11.8	0.1	0.9	26.31	91.7	6.324	55.1014
2025	10	29	8	0	0	11.8	0.1	0.9	26.75	93.6	6.324	55.9395

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	29	8	10	0	12.2	0.1	0.9	25.56	93.8	6.324	53.4253
2025	10	29	8	20	0	12.6	0.1	0.9	25.74	93.3	6.324	53.8444
2025	10	29	8	30	0	12.8	0.1	0.9	25.52	92.5	6.324	53.4254
2025	10	29	8	40	0	13	0.1	0.9	27.08	94.4	6.324	56.568
2025	10	29	8	50	0	13	0.1	0.9	26.37	94.1	6.3301	55.1569
2025	10	29	9	0	0	13	0.1	0.9	27.53	92.7	6.3301	57.6735
2025	10	29	9	10	0	13	0.1	0.9	25	95	6.3301	52.2207
2025	10	29	9	20	0	13	0.1	0.9	27.67	93.9	6.3301	57.8832
2025	10	29	9	30	0	13	0.1	0.9	27.03	92.8	6.3301	56.6249
2025	10	29	9	40	0	13.2	0.1	0.9	25.14	93.4	6.3301	52.6401
2025	10	29	9	50	0	13.2	0.1	0.9	25.93	92.7	6.3301	54.3179
2025	10	29	10	0	0	13.4	0.1	0.9	26.5	95	6.3301	55.3665
2025	10	29	10	10	0	13.4	0.1	0.9	27.38	94.4	6.3301	57.2539
2025	10	29	10	20	0	13.4	0.1	0.9	27.26	93.8	6.3301	57.0442
2025	10	29	10	30	0	13.4	0.1	0.9	27.45	93.3	6.3301	57.4636
2025	10	29	10	40	0	13.4	0.1	0.9	25.43	92.9	6.3301	53.2691
2025	10	29	10	50	0	13.4	0.1	0.9	26.55	93.7	6.3301	55.576
2025	10	29	11	0	0	14.2	0.1	0.9	26.68	94.5	6.3301	55.7857
2025	10	29	11	10	0	14.2	0.1	0.9	26.35	93.5	6.3301	55.1565
2025	10	29	11	20	0	14.2	0.1	0.9	26.25	93.5	6.3301	54.9467
2025	10	29	11	30	0	14.2	0.1	0.9	26.65	93.7	6.3301	55.7856
2025	10	29	11	40	0	14.2	0.1	0.9	26.27	94.1	6.3301	54.9466
2025	10	29	11	50	0	14.2	0.1	0.9	25.12	92.1	6.3301	52.6397
2025	10	29	12	0	0	14.2	0.1	0.9	26.89	94.7	6.3301	56.2048
2025	10	29	12	10	0	14.2	0.1	0.9	27.25	93.4	6.3301	57.0437
2025	10	29	12	20	0	14.2	0.1	0.9	26.27	94.1	6.324	54.8912
2025	10	29	12	30	0	14.2	0.1	0.9	26.43	92.6	6.3179	55.2546
2025	10	29	12	40	0	14.2	0.1	0.9	26.97	94.3	6.3179	56.301
2025	10	29	12	50	0	14.2	0.1	0.9	26.11	95.3	6.324	54.472
2025	10	29	13	0	0	14.2	0.1	0.9	26.43	92.6	6.324	55.31
2025	10	29	13	10	0	14.2	0.1	0.9	26.58	94.5	6.3179	55.4636
2025	10	29	13	20	0	14.2	0.1	0.9	25.23	93	6.3179	52.7427
2025	10	29	13	30	0	14.2	0.1	0.9	26.3	91.1	6.3179	55.0449
2025	10	29	13	40	0	14.2	0.1	0.9	26.32	92.2	6.3179	55.0449
2025	10	29	13	50	0	14.2	0.1	0.9	26.86	93.8	6.3179	56.0913
2025	10	29	14	0	0	14.2	0.1	0.9	26.85	93.6	6.3179	56.0913
2025	10	29	14	10	0	14.2	0.1	0.9	26.83	95.6	6.3179	55.8819
2025	10	29	14	20	0	14.2	0.1	0.9	27.02	92.3	6.3179	56.5098
2025	10	29	14	30	0	14.2	0.1	0.9	27.8	95	6.3179	57.9748
2025	10	29	14	40	0	14.2	0.1	0.9	26.4	90.9	6.3179	55.2539
2025	10	29	14	50	0	14.2	0.1	0.9	25.84	93.1	6.324	54.0525
2025	10	29	15	0	0	14.2	0.1	0.9	26.56	93.9	6.324	55.519
2025	10	29	15	10	0	14.2	0.1	0.9	26.68	94.5	6.324	55.7284
2025	10	29	15	20	0	13.2	0.1	0.9	27.14	93	6.324	56.7759
2025	10	29	15	30	0	13.2	0.1	0.9	26.53	95.6	6.324	55.3094
2025	10	29	15	40	0	13.2	0.1	0.9	26.72	92.4	6.324	55.9378
2025	10	29	15	50	0	13.2	0.1	0.9	27.79	94.5	6.324	58.0329
2025	10	29	16	0	0	13.2	0.1	0.9	27.45	93.3	6.324	57.4043

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	29	16	10	0	13.2	0.1	0.9	27.29	96.7	6.324	56.7758
2025	10	29	16	20	0	13.2	0.1	0.9	26.82	91.9	6.324	56.1473
2025	10	29	16	30	0	13.2	0.1	0.9	26.26	93.7	6.324	54.8902
2025	10	29	16	40	0	13.2	0.1	0.9	27.17	94	6.324	56.7757
2025	10	29	16	50	0	13.2	0.1	0.9	27.63	92.7	6.324	57.8232
2025	10	29	17	0	0	13.2	0.1	0.9	26.91	95.1	6.324	56.1472
2025	10	29	17	10	0	13	0.1	0.9	26.58	94.3	6.324	55.5187
2025	10	29	17	20	0	12.4	0.1	0.9	27.67	93.9	6.324	57.8232
2025	10	29	17	30	0	12.2	0.1	0.9	25.56	93.8	6.324	53.4236
2025	10	29	17	40	0	12.2	0.1	0.9	26.74	93.2	6.324	55.9377
2025	10	29	17	50	0	12.2	0.1	0.9	26.6	95	6.3301	55.5745
2025	10	29	18	0	0	12.2	0.1	0.9	27.04	93.2	6.3301	56.6231
2025	10	29	18	10	0	12.2	0.1	0.9	27.65	93.5	6.3301	57.8814
2025	10	29	18	20	0	12.2	0.1	0.9	26.31	91.7	6.324	55.0997
2025	10	29	18	30	0	12.2	0.1	0.9	27.23	95.7	6.324	56.7757
2025	10	29	18	40	0	12.2	0.1	0.9	26.43	92.8	6.3301	55.3648
2025	10	29	18	50	0	12.2	0.1	0.9	26.92	95.3	6.3301	56.2037
2025	10	29	19	0	0	12.2	0.1	0.9	27.65	93.5	6.324	57.8233
2025	10	29	19	10	0	12.2	0.1	0.9	26.52	91.9	6.324	55.5188
2025	10	29	19	20	0	12	0.1	0.9	26.74	93.2	6.324	55.9378
2025	10	29	19	30	0	12	0.1	0.9	26.54	93.2	6.324	55.5188
2025	10	29	19	40	0	12	0.1	0.9	26.12	92	6.324	54.6808
2025	10	29	19	50	0	12	0.1	0.9	26.12	92	6.324	54.6809
2025	10	29	20	0	0	12	0.1	0.9	26.83	92.6	6.324	56.1474
2025	10	29	20	10	0	12	0.1	0.9	27.47	94	6.324	57.4045
2025	10	29	20	20	0	12	0.1	0.9	27.11	91.7	6.324	56.776
2025	10	29	20	30	0	12	0.1	0.9	27.13	92.7	6.324	56.776
2025	10	29	20	40	0	12	0.1	0.9	27.18	94.4	6.324	56.7761
2025	10	29	20	50	0	12	0.1	0.9	26.38	94.3	6.3179	55.0447
2025	10	29	21	0	0	12	0.1	0.9	27.55	93.5	6.3179	57.5563
2025	10	29	21	10	0	12	0.1	0.9	27.47	94	6.3179	57.347
2025	10	29	21	20	0	12	0.1	0.9	26.98	94.5	6.3179	56.3005
2025	10	29	21	30	0	12	0.1	0.9	26.75	93.6	6.3179	55.882
2025	10	29	21	40	0	12	0.1	0.9	26.12	92	6.3179	54.6262
2025	10	29	21	50	0	12	0.1	0.9	26.87	94.3	6.3118	56.0349
2025	10	29	22	0	0	12	0.1	0.9	26.64	93.2	6.3118	55.6168
2025	10	29	22	10	0	12	0.1	0.9	26.16	93.9	6.3118	54.5714
2025	10	29	22	20	0	12	0.1	0.9	26.54	93	6.3118	55.4077
2025	10	29	22	30	0	12	0.1	0.9	26.12	92.4	6.3118	54.5714
2025	10	29	22	40	0	12	0.1	0.9	25.83	95.8	6.3118	53.7351
2025	10	29	22	50	0	12	0.1	0.9	25.52	92	6.3118	53.317
2025	10	29	23	0	0	12	0.1	0.9	25.62	92	6.3118	53.5261
2025	10	29	23	10	0	12	0.1	0.9	27.59	94.6	6.3118	57.4988
2025	10	29	23	20	0	12	0.1	0.9	27.12	92.1	6.3118	56.6625
2025	10	29	23	30	0	12	0.1	0.9	26.71	91.3	6.3057	55.7699
2025	10	29	23	40	0	12	0.1	0.9	26.45	93.5	6.3057	55.1433
2025	10	29	23	50	0	12	0.1	0.9	26.42	92.2	6.3057	55.1433
2025	10	30	0	0	0	12	0.1	0.9	27	90.8	6.3057	56.3966

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	30	0	10	0	12	0.1	0.9	27.45	93.6	6.3057	57.2322
2025	10	30	0	20	0	12	0.1	0.9	26.86	93.8	6.3057	55.9789
2025	10	30	0	30	0	12	0.1	0.9	25.92	92.2	6.3057	54.0991
2025	10	30	0	40	0	12	0.1	0.9	26.75	93.6	6.3057	55.7701
2025	10	30	0	50	0	12	0.1	0.9	25.98	94.6	6.3057	54.0991
2025	10	30	1	0	0	12	0.1	0.9	25.42	92	6.3057	53.0548
2025	10	30	1	10	0	12	0.1	0.9	26.48	94.3	6.3057	55.1436
2025	10	30	1	20	0	12	0.1	0.9	26.42	92.2	6.2996	55.088
2025	10	30	1	30	0	12	0.1	0.9	27.46	93.8	6.3057	57.2324
2025	10	30	1	40	0	12	0.1	0.9	27.12	92.3	6.3057	56.6058
2025	10	30	1	50	0	12	0.1	0.9	27.05	93.4	6.2996	56.3401
2025	10	30	2	0	0	12	0.1	0.9	25.64	93.4	6.2996	53.4187
2025	10	30	2	10	0	12	0.1	0.9	26.22	95.5	6.2996	54.4621
2025	10	30	2	20	0	12	0.1	0.9	26.7	94.9	6.2996	55.5055
2025	10	30	2	30	0	11.8	0.1	0.9	26.5	95	6.2996	55.0881
2025	10	30	2	40	0	11.8	0.1	0.9	26.32	92.4	6.2996	54.8795
2025	10	30	2	50	0	11.8	0.1	0.9	26.61	95.2	6.2996	55.2968
2025	10	30	3	0	0	11.8	0.1	0.9	26.77	94.3	6.2996	55.7142
2025	10	30	3	10	0	11.8	0.1	0.9	26.83	92.8	6.2996	55.9229
2025	10	30	3	20	0	11.8	0.1	0.9	27.02	95.3	6.2996	56.1316
2025	10	30	3	30	0	11.8	0.1	0.9	25.96	96.4	6.2996	53.8363
2025	10	30	3	40	0	11.8	0.1	0.9	25.89	94.9	6.2996	53.8363
2025	10	30	3	50	0	11.8	0.1	0.9	25.56	93.8	6.2935	53.1566
2025	10	30	4	0	0	11.8	0.1	0.9	26.04	93.1	6.2935	54.1989
2025	10	30	4	10	0	11.8	0.1	0.9	26.88	94.5	6.2935	55.8665
2025	10	30	4	20	0	11.8	0.1	0.9	27.04	93.2	6.2935	56.2835
2025	10	30	4	30	0	11.8	0.1	0.9	26.85	93.4	6.2935	55.8666
2025	10	30	4	40	0	11.8	0.1	0.9	27.17	94	6.2935	56.492
2025	10	30	4	50	0	11.8	0.1	0.9	26.62	95.4	6.2935	55.2412
2025	10	30	5	0	0	11.8	0.1	0.9	26.14	93.1	6.2935	54.4074
2025	10	30	5	10	0	11.8	0.1	0.9	25.42	92.3	6.2935	52.9482
2025	10	30	5	20	0	11.8	0.1	0.9	26.58	94.3	6.2935	55.2413
2025	10	30	5	30	0	11.8	0.1	0.9	26.95	93.6	6.2935	56.0751
2025	10	30	5	40	0	11.8	0.1	0.9	26.45	93.7	6.2935	55.0329
2025	10	30	5	50	0	11.8	0.1	0.9	27.38	94.4	6.2935	56.909
2025	10	30	6	0	0	11.8	0.1	0.9	26.98	96.6	6.2935	55.8667
2025	10	30	6	10	0	11.8	0.1	0.9	26.63	95.6	6.2935	55.2414
2025	10	30	6	20	0	11.8	0.1	0.9	26.99	94.7	6.2935	56.0752
2025	10	30	6	30	0	11.8	0.1	0.9	26.12	92.4	6.2935	54.4076
2025	10	30	6	40	0	11.8	0.1	0.9	25.94	93.3	6.2935	53.9907
2025	10	30	6	50	0	11.8	0.1	0.9	26.15	96.1	6.2935	54.1991
2025	10	30	7	0	0	11.8	0.1	0.9	26.34	93	6.2935	54.8245
2025	10	30	7	10	0	11.8	0.1	0.9	26.88	94.5	6.2935	55.8668
2025	10	30	7	20	0	11.8	0.1	0.9	26.62	92.4	6.2935	55.4499
2025	10	30	7	30	0	11.8	0.1	0.9	27.21	91.5	6.2935	56.7007
2025	10	30	7	40	0	11.8	0.1	0.9	26.73	92.8	6.2935	55.6584
2025	10	30	7	50	0	11.6	0.1	0.9	27.53	92.7	6.2935	57.3261
2025	10	30	8	0	0	11.8	0.1	0.9	26.26	93.9	6.2935	54.6161

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	30	8	10	0	12.2	0.1	0.9	25.91	95.3	6.2935	53.7823
2025	10	30	8	20	0	12.6	0.1	0.9	25.58	94.5	6.2935	53.1569
2025	10	30	8	30	0	12.8	0.1	0.9	27.22	95.3	6.2935	56.4923
2025	10	30	8	40	0	13	0.1	0.9	26.95	93.4	6.2935	56.0754
2025	10	30	8	50	0	13	0.1	0.9	26.32	92.4	6.2935	54.8246
2025	10	30	9	0	0	13	0.1	0.9	25.61	91.3	6.2935	53.3654
2025	10	30	9	10	0	13	0.1	0.9	25.73	97.6	6.2935	53.1569
2025	10	30	9	20	0	13	0.1	0.9	25.64	93.1	6.2935	53.3654
2025	10	30	9	30	0	13.2	0.1	0.9	26.01	95.3	6.2935	53.9907
2025	10	30	9	40	0	13.2	0.1	0.9	25.89	94.7	6.2935	53.7822
2025	10	30	9	50	0	13.4	0.1	0.9	25.63	92.7	6.2935	53.3653
2025	10	30	10	0	0	13.6	0.1	0.9	26.98	94.5	6.2935	56.0752
2025	10	30	10	10	0	13.6	0.1	0.9	25.94	93.3	6.2935	53.9906
2025	10	30	10	20	0	13.6	0.1	0.9	25.41	91.6	6.2935	52.9483
2025	10	30	10	30	0	14.2	0.1	0.9	26.72	95.4	6.2935	55.4497
2025	10	30	10	40	0	14.2	0.1	0.9	26.08	94.6	6.2935	54.1989
2025	10	30	10	50	0	14.2	0.1	0.9	26.58	94.5	6.2935	55.2412
2025	10	30	11	0	0	14.2	0.1	0.9	26.33	92.8	6.2935	54.8242
2025	10	30	11	10	0	14.2	0.1	0.9	26.04	93.1	6.2935	54.1988
2025	10	30	11	20	0	14.2	0.1	0.9	25.75	93.6	6.2935	53.5733
2025	10	30	11	30	0	14.2	0.1	0.9	26.95	93.6	6.2935	56.0748
2025	10	30	11	40	0	14.2	0.1	0.9	26.13	92.9	6.2935	54.4071
2025	10	30	11	50	0	14.2	0.1	0.9	24.98	94.6	6.2935	51.9055
2025	10	30	12	0	0	14.2	0.1	0.9	25.4	95	6.2935	52.7393
2025	10	30	12	10	0	14.2	0.1	0.9	26.07	96.6	6.2935	53.99
2025	10	30	12	20	0	13.4	0.1	0.9	26.65	93.7	6.2935	55.4491
2025	10	30	12	30	0	14.2	0.1	0.9	27.39	96.7	6.2996	56.7571
2025	10	30	12	40	0	14.2	0.1	0.9	26.42	95.4	6.2996	54.8791
2025	10	30	12	50	0	14.2	0.1	0.9	26.93	95.5	6.2996	55.9223
2025	10	30	13	0	0	14.2	0.1	0.9	25.62	95.6	6.2996	53.2096
2025	10	30	13	10	0	14.2	0.1	0.9	26.25	93.5	6.2996	54.6702
2025	10	30	13	20	0	14.2	0.1	0.9	27.13	92.5	6.2996	56.5482
2025	10	30	13	30	0	14.2	0.1	0.9	24.99	94.8	6.2996	51.9575
2025	10	30	13	40	0	14.2	0.1	0.9	25.17	94.3	6.2996	52.3748
2025	10	30	13	50	0	14.2	0.1	0.9	26.02	92.2	6.2996	54.2527
2025	10	30	14	0	0	14.2	0.1	0.9	26.58	94.3	6.2996	55.296
2025	10	30	14	10	0	14.2	0.1	0.9	24.89	94.8	6.2996	51.7487
2025	10	30	14	20	0	14	0.1	0.9	26.54	95.8	6.2996	55.0872
2025	10	30	14	30	0	14.2	0.1	0.9	26.36	96.3	6.3057	54.7251
2025	10	30	14	40	0	14.2	0.1	0.9	26.56	93.9	6.3057	55.3516
2025	10	30	14	50	0	14.2	0.1	0.9	26.55	93.7	6.3057	55.3516
2025	10	30	15	0	0	14	0.1	0.9	25.67	94.2	6.3057	53.4717
2025	10	30	15	10	0	14	0.1	0.9	26.74	93.2	6.3057	55.7693
2025	10	30	15	20	0	13.2	0.1	0.9	27.22	95.3	6.3057	56.6048
2025	10	30	15	30	0	13.2	0.1	0.9	26.35	93.7	6.3057	54.9338
2025	10	30	15	40	0	13.8	0.1	0.9	27.04	93.2	6.3057	56.3958
2025	10	30	15	50	0	13.8	0.1	0.9	27.06	93.8	6.3057	56.3958
2025	10	30	16	0	0	13.6	0.1	0.9	27.15	93.6	6.3057	56.6047

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	30	16	10	0	13.6	0.1	0.9	26.58	96.7	6.3057	55.1426
2025	10	30	16	20	0	13.2	0.1	0.9	26.56	93.9	6.3057	55.3514
2025	10	30	16	30	0	13.2	0.1	0.9	26.65	93.4	6.3057	55.5603
2025	10	30	16	40	0	13.2	0.1	0.9	27.13	92.5	6.3057	56.6046
2025	10	30	16	50	0	13.2	0.1	0.9	26.61	91.7	6.3118	55.6163
2025	10	30	17	0	0	13.2	0.1	0.9	25.53	95.8	6.3118	53.1073
2025	10	30	17	10	0	12.8	0.1	0.9	28.05	93.5	6.3118	58.5435
2025	10	30	17	20	0	12.2	0.1	0.9	27.17	94	6.3118	56.6617
2025	10	30	17	30	0	12.2	0.1	0.9	26.67	94.1	6.3118	55.6163
2025	10	30	17	40	0	12.2	0.1	0.9	27.01	95.1	6.3118	56.2435
2025	10	30	17	50	0	12.2	0.1	0.9	27.58	94.4	6.3118	57.498
2025	10	30	18	0	0	12.2	0.1	0.9	27.83	92.7	6.3118	58.1253
2025	10	30	18	10	0	12.2	0.1	0.9	26.33	92.8	6.3118	54.989
2025	10	30	18	20	0	12.2	0.1	0.9	27.82	92.1	6.3118	58.1253
2025	10	30	18	30	0	12.2	0.1	0.9	27.47	94	6.3118	57.289
2025	10	30	18	40	0	12.2	0.1	0.9	27.25	96.1	6.3118	56.6617
2025	10	30	18	50	0	12.2	0.1	0.9	26.67	96.5	6.3118	55.4073
2025	10	30	19	0	0	12.2	0.1	0.9	25.82	95.6	6.3118	53.7346
2025	10	30	19	10	0	12	0.1	0.9	27.47	94	6.3118	57.289
2025	10	30	19	20	0	12	0.1	0.9	27.24	92.9	6.3118	56.8709
2025	10	30	19	30	0	12	0.1	0.9	27.1	94.9	6.3179	56.5096
2025	10	30	19	40	0	12	0.1	0.9	26.73	92.6	6.3118	55.8255
2025	10	30	19	50	0	12	0.1	0.9	26.79	94.7	6.3118	55.8256
2025	10	30	20	0	0	12	0.1	0.9	27.12	95.3	6.3118	56.4528
2025	10	30	20	10	0	12	0.1	0.9	26.83	92.8	6.3118	56.0347
2025	10	30	20	20	0	12	0.1	0.9	26.38	94.3	6.3118	54.9893
2025	10	30	20	30	0	12	0.1	0.9	25.87	94.2	6.3179	53.9983
2025	10	30	20	40	0	12	0.1	0.9	26.56	93.9	6.3118	55.4075
2025	10	30	20	50	0	12	0.1	0.9	27.53	92.7	6.3179	57.5563
2025	10	30	21	0	0	12	0.1	0.9	25.73	92.7	6.3179	53.789
2025	10	30	21	10	0	12	0.1	0.9	25.92	92	6.3179	54.2077
2025	10	30	21	20	0	12	0.1	0.9	26.24	93.1	6.3179	54.8356
2025	10	30	21	30	0	12	0.1	0.9	27.98	94.3	6.3118	58.3349
2025	10	30	21	40	0	12	0.1	0.9	26.72	92.4	6.3179	55.8821
2025	10	30	21	50	0	12	0.1	0.9	26.97	94	6.3179	56.3008
2025	10	30	22	0	0	12	0.1	0.9	27.45	93.6	6.3179	57.3473
2025	10	30	22	10	0	12	0.1	0.9	27.07	94	6.3179	56.5101
2025	10	30	22	20	0	12	0.1	0.9	26.95	93.6	6.3179	56.3008
2025	10	30	22	30	0	12	0.1	0.9	26.38	94.3	6.3179	55.0451
2025	10	30	22	40	0	12	0.1	0.9	26.55	93.5	6.3179	55.4637
2025	10	30	22	50	0	12	0.1	0.9	26.84	93.2	6.3179	56.0916
2025	10	30	23	0	0	12	0.1	0.9	27.98	94.3	6.3179	58.3939
2025	10	30	23	10	0	12	0.1	0.9	26.62	92.2	6.3179	55.6731
2025	10	30	23	20	0	12	0.1	0.9	26.27	94.1	6.324	54.8911
2025	10	30	23	30	0	12	0.1	0.9	26.02	92.4	6.324	54.4721
2025	10	30	23	40	0	12	0.1	0.9	27.5	90.8	6.324	57.6148
2025	10	30	23	50	0	12	0.1	0.9	25.94	93.1	6.324	54.2627
2025	10	31	0	0	0	12	0.1	0.9	26.84	93	6.3301	56.2048

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	31	0	10	0	12	0.1	0.9	26.57	94.1	6.324	55.5198
2025	10	31	0	20	0	12	0.1	0.9	25.24	93.2	6.3301	52.8493
2025	10	31	0	30	0	12	0.1	0.9	26.96	93.8	6.3301	56.4146
2025	10	31	0	40	0	12	0.1	0.9	25.96	94	6.3301	54.3174
2025	10	31	0	50	0	12	0.1	0.9	26.89	94.7	6.3301	56.2049
2025	10	31	1	0	0	12	0.1	0.9	26.26	93.9	6.3301	54.9466
2025	10	31	1	10	0	12	0.1	0.9	27.52	97.3	6.3301	57.2536
2025	10	31	1	20	0	12	0.1	0.9	26.88	94.5	6.3301	56.205
2025	10	31	1	30	0	12	0.1	0.9	26.46	93.9	6.3301	55.3662
2025	10	31	1	40	0	11.8	0.1	0.9	27.08	94.4	6.3301	56.6245
2025	10	31	1	50	0	11.8	0.1	0.9	25.92	92	6.3301	54.3176
2025	10	31	2	0	0	11.8	0.1	0.9	26.75	96	6.3301	55.7857
2025	10	31	2	10	0	11.8	0.1	0.9	27.06	93.8	6.3301	56.6246
2025	10	31	2	20	0	11.8	0.1	0.9	26.98	94.5	6.3301	56.4149
2025	10	31	2	30	0	11.8	0.1	0.9	26.61	97.1	6.3301	55.3663
2025	10	31	2	40	0	11.8	0.1	0.9	26.81	91.3	6.3301	56.2052
2025	10	31	2	50	0	11.8	0.1	0.9	26.83	92.8	6.3301	56.2052
2025	10	31	3	0	0	11.8	0.1	0.9	27.27	96.3	6.3301	56.8344
2025	10	31	3	10	0	11.8	0.1	0.9	27.28	94.4	6.3301	57.0442
2025	10	31	3	20	0	11.8	0.1	0.9	27.44	92.9	6.3301	57.4636
2025	10	31	3	30	0	11.8	0.1	0.9	26.57	94.1	6.3301	55.5761
2025	10	31	3	40	0	11.8	0.1	0.9	26.48	94.3	6.3301	55.3664
2025	10	31	3	50	0	11.8	0.1	0.9	25.72	95.6	6.3301	53.6887
2025	10	31	4	0	0	11.8	0.1	0.9	26.88	94.5	6.3301	56.2054
2025	10	31	4	10	0	11.8	0.1	0.9	27.27	94.2	6.3301	57.0443
2025	10	31	4	20	0	11.8	0.1	0.9	25.66	93.8	6.3301	53.6887
2025	10	31	4	30	0	11.8	0.1	0.9	25.98	94.4	6.3301	54.3179
2025	10	31	4	40	0	11.8	0.1	0.9	26.61	91.3	6.3301	55.786
2025	10	31	4	50	0	11.8	0.1	0.9	27.23	92.5	6.3301	57.0443
2025	10	31	5	0	0	11.8	0.1	0.9	25.63	92.9	6.3301	53.6888
2025	10	31	5	10	0	11.8	0.1	0.9	27.19	94.6	6.3301	56.8346
2025	10	31	5	20	0	11.8	0.1	0.9	27	94.9	6.3301	56.4152
2025	10	31	5	30	0	11.8	0.1	0.9	27.78	94.3	6.3301	58.093
2025	10	31	5	40	0	11.8	0.1	0.9	26.65	93.7	6.3301	55.786
2025	10	31	5	50	0	11.8	0.1	0.9	26.77	94.3	6.3301	55.9958
2025	10	31	6	0	0	11.8	0.1	0.9	26.08	94.4	6.3301	54.5277
2025	10	31	6	10	0	11.8	0.1	0.9	27.18	96.5	6.3301	56.625
2025	10	31	6	20	0	11.8	0.1	0.9	26.82	92.4	6.3301	56.2055
2025	10	31	6	30	0	11.8	0.1	0.9	26.02	92	6.3301	54.5278
2025	10	31	6	40	0	11.8	0.1	0.9	28.18	94.3	6.3301	58.932
2025	10	31	6	50	0	11.8	0.1	0.9	26.52	95.4	6.3301	55.3667
2025	10	31	7	0	0	11.8	0.1	0.9	26.77	94.3	6.3301	55.9959
2025	10	31	7	10	0	11.8	0.1	0.9	26.6	95	6.3301	55.5764
2025	10	31	7	20	0	11.6	0.1	0.9	26.71	95.2	6.3301	55.7862
2025	10	31	7	30	0	11.6	0.1	0.9	26.44	93	6.3301	55.3667
2025	10	31	7	40	0	11.6	0.1	0.9	26.68	94.5	6.3301	55.7862
2025	10	31	7	50	0	11.6	0.1	0.9	27.25	93.4	6.3301	57.0445
2025	10	31	8	0	0	11.6	0.1	0.9	25.3	95	6.3301	52.8501

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	31	8	10	0	12.2	0.1	0.9	27.08	94.4	6.3301	56.6251
2025	10	31	8	20	0	12.6	0.1	0.9	26.6	95	6.3301	55.5765
2025	10	31	8	30	0	12.8	0.1	0.9	26.75	93.6	6.3301	55.996
2025	10	31	8	40	0	13	0.1	0.9	27.78	94.3	6.3301	58.0932
2025	10	31	8	50	0	13	0.1	0.9	26.67	94.1	6.3301	55.7862
2025	10	31	9	0	0	13	0.1	0.9	26.99	94.7	6.3301	56.4154
2025	10	31	9	10	0	13	0.1	0.9	26.85	93.6	6.3301	56.2057
2025	10	31	9	20	0	13	0.1	0.9	26.13	95.7	6.3301	54.5279
2025	10	31	9	30	0	13.4	0.1	0.9	26.99	94.7	6.3301	56.4153
2025	10	31	9	40	0	13.4	0.1	0.9	27.28	94.4	6.3301	57.0445
2025	10	31	9	50	0	13.4	0.1	0.9	26.9	94.9	6.3301	56.2056
2025	10	31	10	0	0	13.4	0.1	0.9	25.83	95.8	6.3301	53.8986
2025	10	31	10	10	0	13.4	0.1	0.9	25.73	92.7	6.3301	53.8986
2025	10	31	10	20	0	13.4	0.1	0.9	26.26	93.9	6.3301	54.9472
2025	10	31	10	30	0	13.6	0.1	0.9	27.34	95.9	6.3301	57.0443
2025	10	31	10	40	0	13.8	0.1	0.9	27.14	93	6.3301	56.8346
2025	10	31	10	50	0	13.8	0.1	0.9	26.65	96	6.3301	55.5762
2025	10	31	11	0	0	14	0.1	0.9	27.78	94.3	6.3301	58.0928
2025	10	31	11	10	0	14.2	0.1	0.9	25.82	95.6	6.3301	53.8983
2025	10	31	11	20	0	14.2	0.1	0.9	25.72	92.5	6.3301	53.8983
2025	10	31	11	30	0	14.2	0.1	0.9	27.34	95.9	6.3301	57.044
2025	10	31	11	40	0	14.2	0.1	0.9	26.62	95.4	6.3301	55.5759
2025	10	31	11	50	0	14.2	0.1	0.9	26.34	93	6.324	55.101
2025	10	31	12	0	0	14.2	0.1	0.9	26.38	94.6	6.3179	55.0456
2025	10	31	12	10	0	14.2	0.1	0.9	25.23	95.9	6.3179	52.5339
2025	10	31	12	20	0	14.2	0.1	0.9	26.4	95	6.3179	55.0454
2025	10	31	12	30	0	14.2	0.1	0.9	26.39	94.8	6.3118	54.99
2025	10	31	12	40	0	14.2	0.1	0.9	27	94.9	6.3118	56.2444
2025	10	31	12	50	0	14.2	0.1	0.9	26.18	94.4	6.3118	54.5717
2025	10	31	13	0	0	14.2	0.1	0.9	26.79	94.7	6.3118	55.8262
2025	10	31	13	10	0	14.2	0.1	0.9	26.03	95.7	6.3118	54.1534
2025	10	31	13	20	0	14.2	0.1	0.9	25.66	94	6.3118	53.5261
2025	10	31	13	30	0	14.2	0.1	0.9	26.09	94.8	6.3118	54.3624
2025	10	31	13	40	0	14.2	0.1	0.9	27	94.9	6.3118	56.2441
2025	10	31	13	50	0	14.2	0.1	0.9	25.43	95.9	6.3118	52.8987
2025	10	31	14	0	0	14.2	0.1	0.9	26.53	95.6	6.3179	55.2542
2025	10	31	14	10	0	14.2	0.1	0.9	25.36	96.3	6.3118	52.6895
2025	10	31	14	20	0	13.2	0.1	0.9	26.69	94.7	6.3118	55.6167
2025	10	31	14	30	0	13.2	0.1	0.9	26.03	92.9	6.3118	54.3621
2025	10	31	14	40	0	13.2	0.1	0.9	26.33	95.7	6.3179	54.8354
2025	10	31	14	50	0	13.2	0.1	0.9	25.97	94.2	6.3179	54.2075
2025	10	31	15	0	0	13.2	0.1	0.9	27.93	92.7	6.3118	58.3346
2025	10	31	15	10	0	13.2	0.1	0.9	25.92	95.5	6.3118	53.9438
2025	10	31	15	20	0	13.2	0.1	0.9	26.99	94.7	6.3118	56.2436
2025	10	31	15	30	0	13.2	0.1	0.9	26.47	96.5	6.3118	54.9891
2025	10	31	15	40	0	13.2	0.1	0.9	26.87	98.1	6.3118	55.6163
2025	10	31	15	50	0	13.2	0.1	0.9	26.34	93	6.3118	54.9891
2025	10	31	16	0	0	13.2	0.1	0.9	26.58	96.7	6.3118	55.1981

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	10	31	16	10	0	13	0.1	0.9	26.45	93.5	6.3179	55.2537
2025	10	31	16	20	0	13	0.1	0.9	27.07	94.2	6.3179	56.5095
2025	10	31	16	30	0	13	0.1	0.9	26.45	93.5	6.3179	55.2537
2025	10	31	16	40	0	13	0.1	0.9	26.38	94.6	6.3179	55.0444
2025	10	31	16	50	0	13.2	0.1	0.9	26.23	95.7	6.3179	54.6258
2025	10	31	17	0	0	13.2	0.1	0.9	25.99	94.9	6.3179	54.2071
2025	10	31	17	10	0	12.8	0.1	0.9	25.92	92	6.3179	54.2071
2025	10	31	17	20	0	12.2	0.1	0.9	25.99	94.9	6.3179	54.2071
2025	10	31	17	30	0	12.2	0.1	0.9	26.47	94.1	6.3179	55.2536
2025	10	31	17	40	0	12.2	0.1	0.9	26.76	96.2	6.3179	55.6722
2025	10	31	17	50	0	12.2	0.1	0.9	25.72	92.2	6.3179	53.7885
2025	10	31	18	0	0	12.2	0.1	0.9	27.23	92.7	6.3179	56.9279
2025	10	31	18	10	0	12.2	0.1	0.9	26.98	94.5	6.3179	56.3001
2025	10	31	18	20	0	12.2	0.1	0.9	26.23	92.6	6.3179	54.835
2025	10	31	18	30	0	12.2	0.1	0.9	26.87	94.3	6.3179	56.0908
2025	10	31	18	40	0	12.2	0.1	0.9	26.1	90.2	6.3179	54.6258
2025	10	31	18	50	0	12.2	0.1	0.9	27.33	92.7	6.3179	57.1373
2025	10	31	19	0	0	12.2	0.1	0.9	26.35	93.7	6.3179	55.0444
2025	10	31	19	10	0	12.2	0.1	0.9	28.37	94	6.3179	59.2303
2025	10	31	19	20	0	12.2	0.1	0.9	26.95	93.6	6.3179	56.3002
2025	10	31	19	30	0	12	0.1	0.9	26.24	93.3	6.3179	54.8352
2025	10	31	19	40	0	12	0.1	0.9	26.77	94.1	6.3179	55.8817
2025	10	31	19	50	0	12	0.1	0.9	26.95	93.4	6.3179	56.3003
2025	10	31	20	0	0	12	0.1	0.9	26.73	92.6	6.3179	55.8817
2025	10	31	20	10	0	12	0.1	0.9	26.35	96.1	6.3179	54.8353
2025	10	31	20	20	0	12	0.1	0.9	25.3	97.3	6.3179	52.5331
2025	10	31	20	30	0	12	0.1	0.9	26.01	95.3	6.3179	54.2075
2025	10	31	20	40	0	12	0.1	0.9	26.24	93.1	6.3118	54.7802
2025	10	31	20	50	0	12	0.1	0.9	27.35	93.6	6.3118	57.0802
2025	10	31	21	0	0	12	0.1	0.9	25.7	90	6.3179	53.789
2025	10	31	21	10	0	12	0.1	0.9	27.88	94.3	6.3118	58.1257
2025	10	31	21	20	0	12	0.1	0.9	25.9	90.9	6.3118	54.1531
2025	10	31	21	30	0	12	0.1	0.9	26.93	92.8	6.3118	56.244
2025	10	31	21	40	0	12	0.1	0.9	25.94	93.1	6.3118	54.1531
2025	10	31	21	50	0	12	0.1	0.9	26.08	94.6	6.3179	54.417
2025	10	31	22	0	0	12	0.1	0.9	26.12	92	6.3118	54.5714
2025	10	31	22	10	0	12	0.1	0.9	26.55	93.5	6.3118	55.4078
2025	10	31	22	20	0	12	0.1	0.9	27.05	93.4	6.3118	56.4532
2025	10	31	22	30	0	12	0.1	0.9	26.03	95.7	6.3118	54.1533
2025	10	31	22	40	0	12	0.1	0.9	26.48	94.5	6.3118	55.1988
2025	10	31	22	50	0	12	0.1	0.9	26.1	90.4	6.3118	54.5715
2025	10	31	23	0	0	12	0.1	0.9	26.64	93.2	6.3118	55.617
2025	10	31	23	10	0	12	0.1	0.9	24.72	92.5	6.3118	51.6444
2025	10	31	23	20	0	12	0.1	0.9	26.29	94.8	6.3118	54.7807
2025	10	31	23	30	0	12	0.1	0.9	26.52	91.9	6.3057	55.3522
2025	10	31	23	40	0	12	0.1	0.9	25.5	90.7	6.3057	53.2634
2025	10	31	23	50	0	12	0.1	0.9	27.65	93.3	6.3057	57.6499

Locust Ditch Return
Station 0215

Date	Flow (cfs)
10/1/2025	0
10/2/2025	0
10/3/2025	0
10/4/2025	0
10/5/2025	0
10/6/2025	0
10/7/2025	0
10/8/2025	0
10/9/2025	0
10/10/2025	0
10/11/2025	0
10/12/2025	0
10/13/2025	0
10/14/2025	0
10/15/2025	0
10/16/2025	0
10/17/2025	0
10/18/2025	0
10/19/2025	0
10/20/2025	0
10/21/2025	0
10/22/2025	0
10/23/2025	0
10/24/2025	0
10/25/2025	0
10/26/2025	0
10/27/2025	0
10/28/2025	0
10/29/2025	0
10/30/2025	0
10/31/2025	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/1/2025	12:00:00 AM	0
10/1/2025	12:15:00 AM	0
10/1/2025	12:30:00 AM	0
10/1/2025	12:45:00 AM	0
10/1/2025	1:00:00 AM	0
10/1/2025	1:15:00 AM	0
10/1/2025	1:30:00 AM	0
10/1/2025	1:45:00 AM	0
10/1/2025	2:00:00 AM	0
10/1/2025	2:15:00 AM	0
10/1/2025	2:30:00 AM	0
10/1/2025	2:45:00 AM	0
10/1/2025	3:00:00 AM	0
10/1/2025	3:15:00 AM	0
10/1/2025	3:30:00 AM	0
10/1/2025	3:45:00 AM	0
10/1/2025	4:00:00 AM	0
10/1/2025	4:15:00 AM	0
10/1/2025	4:30:00 AM	0
10/1/2025	4:45:00 AM	0
10/1/2025	5:00:00 AM	0
10/1/2025	5:15:00 AM	0
10/1/2025	5:30:00 AM	0
10/1/2025	5:45:00 AM	0
10/1/2025	6:00:00 AM	0
10/1/2025	6:15:00 AM	0
10/1/2025	6:30:00 AM	0
10/1/2025	6:45:00 AM	0
10/1/2025	7:00:00 AM	0
10/1/2025	7:15:00 AM	0
10/1/2025	7:30:00 AM	0
10/1/2025	7:45:00 AM	0
10/1/2025	8:00:00 AM	0
10/1/2025	8:15:00 AM	0
10/1/2025	8:30:00 AM	0
10/1/2025	8:45:00 AM	0
10/1/2025	9:00:00 AM	0
10/1/2025	9:15:00 AM	0
10/1/2025	9:30:00 AM	0
10/1/2025	9:45:00 AM	0
10/1/2025	10:00:00 AM	0
10/1/2025	10:15:00 AM	0
10/1/2025	10:30:00 AM	0
10/1/2025	10:45:00 AM	0
10/1/2025	11:00:00 AM	0
10/1/2025	11:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/1/2025	11:30:00 AM	0
10/1/2025	11:45:00 AM	0
10/1/2025	12:00:00 PM	0
10/1/2025	12:15:00 PM	0
10/1/2025	12:30:00 PM	0
10/1/2025	12:45:00 PM	0
10/1/2025	1:00:00 PM	0
10/1/2025	1:15:00 PM	0
10/1/2025	1:30:00 PM	0
10/1/2025	1:45:00 PM	0
10/1/2025	2:00:00 PM	0
10/1/2025	2:15:00 PM	0
10/1/2025	2:30:00 PM	0
10/1/2025	2:45:00 PM	0
10/1/2025	3:00:00 PM	0
10/1/2025	3:15:00 PM	0
10/1/2025	3:30:00 PM	0
10/1/2025	3:45:00 PM	0
10/1/2025	4:00:00 PM	0
10/1/2025	4:15:00 PM	0
10/1/2025	4:30:00 PM	0
10/1/2025	4:45:00 PM	0
10/1/2025	5:00:00 PM	0
10/1/2025	5:15:00 PM	0
10/1/2025	5:30:00 PM	0
10/1/2025	5:45:00 PM	0
10/1/2025	6:00:00 PM	0
10/1/2025	6:15:00 PM	0
10/1/2025	6:30:00 PM	0
10/1/2025	6:45:00 PM	0
10/1/2025	7:00:00 PM	0
10/1/2025	7:15:00 PM	0
10/1/2025	7:30:00 PM	0
10/1/2025	7:45:00 PM	0
10/1/2025	8:00:00 PM	0
10/1/2025	8:15:00 PM	0
10/1/2025	8:30:00 PM	0
10/1/2025	8:45:00 PM	0
10/1/2025	9:00:00 PM	0
10/1/2025	9:15:00 PM	0
10/1/2025	9:30:00 PM	0
10/1/2025	9:45:00 PM	0
10/1/2025	10:00:00 PM	0
10/1/2025	10:15:00 PM	0
10/1/2025	10:30:00 PM	0
10/1/2025	10:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/1/2025	11:00:00 PM	0
10/1/2025	11:15:00 PM	0
10/1/2025	11:30:00 PM	0
10/1/2025	11:45:00 PM	0
10/2/2025	12:00:00 AM	0
10/2/2025	12:15:00 AM	0
10/2/2025	12:30:00 AM	0
10/2/2025	12:45:00 AM	0
10/2/2025	1:00:00 AM	0
10/2/2025	1:15:00 AM	0
10/2/2025	1:30:00 AM	0
10/2/2025	1:45:00 AM	0
10/2/2025	2:00:00 AM	0
10/2/2025	2:15:00 AM	0
10/2/2025	2:30:00 AM	0
10/2/2025	2:45:00 AM	0
10/2/2025	3:00:00 AM	0
10/2/2025	3:15:00 AM	0
10/2/2025	3:30:00 AM	0
10/2/2025	3:45:00 AM	0
10/2/2025	4:00:00 AM	0
10/2/2025	4:15:00 AM	0
10/2/2025	4:30:00 AM	0
10/2/2025	4:45:00 AM	0
10/2/2025	5:00:00 AM	0
10/2/2025	5:15:00 AM	0
10/2/2025	5:30:00 AM	0
10/2/2025	5:45:00 AM	0
10/2/2025	6:00:00 AM	0
10/2/2025	6:15:00 AM	0
10/2/2025	6:30:00 AM	0
10/2/2025	6:45:00 AM	0
10/2/2025	7:00:00 AM	0
10/2/2025	7:15:00 AM	0
10/2/2025	7:30:00 AM	0
10/2/2025	7:45:00 AM	0
10/2/2025	8:00:00 AM	0
10/2/2025	8:15:00 AM	0
10/2/2025	8:30:00 AM	0
10/2/2025	8:45:00 AM	0
10/2/2025	9:00:00 AM	0
10/2/2025	9:15:00 AM	0
10/2/2025	9:30:00 AM	0
10/2/2025	9:45:00 AM	0
10/2/2025	10:00:00 AM	0
10/2/2025	10:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/2/2025	10:30:00 AM	0
10/2/2025	10:45:00 AM	0
10/2/2025	11:00:00 AM	0
10/2/2025	11:15:00 AM	0
10/2/2025	11:30:00 AM	0
10/2/2025	11:45:00 AM	0
10/2/2025	12:00:00 PM	0
10/2/2025	12:15:00 PM	0
10/2/2025	12:30:00 PM	0
10/2/2025	12:45:00 PM	0
10/2/2025	1:00:00 PM	0
10/2/2025	1:15:00 PM	0
10/2/2025	1:30:00 PM	0
10/2/2025	1:45:00 PM	0
10/2/2025	2:00:00 PM	0
10/2/2025	2:15:00 PM	0
10/2/2025	2:30:00 PM	0
10/2/2025	2:45:00 PM	0
10/2/2025	3:00:00 PM	0
10/2/2025	3:15:00 PM	0
10/2/2025	3:30:00 PM	0
10/2/2025	3:45:00 PM	0
10/2/2025	4:00:00 PM	0
10/2/2025	4:15:00 PM	0
10/2/2025	4:30:00 PM	0
10/2/2025	4:45:00 PM	0
10/2/2025	5:00:00 PM	0
10/2/2025	5:15:00 PM	0
10/2/2025	5:30:00 PM	0
10/2/2025	5:45:00 PM	0
10/2/2025	6:00:00 PM	0
10/2/2025	6:15:00 PM	0
10/2/2025	6:30:00 PM	0
10/2/2025	6:45:00 PM	0
10/2/2025	7:00:00 PM	0
10/2/2025	7:15:00 PM	0
10/2/2025	7:30:00 PM	0
10/2/2025	7:45:00 PM	0
10/2/2025	8:00:00 PM	0
10/2/2025	8:15:00 PM	0
10/2/2025	8:30:00 PM	0
10/2/2025	8:45:00 PM	0
10/2/2025	9:00:00 PM	0
10/2/2025	9:15:00 PM	0
10/2/2025	9:30:00 PM	0
10/2/2025	9:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/2/2025	10:00:00 PM	0
10/2/2025	10:15:00 PM	0
10/2/2025	10:30:00 PM	0
10/2/2025	10:45:00 PM	0
10/2/2025	11:00:00 PM	0
10/2/2025	11:15:00 PM	0
10/2/2025	11:30:00 PM	0
10/2/2025	11:45:00 PM	0
10/3/2025	12:00:00 AM	0
10/3/2025	12:15:00 AM	0
10/3/2025	12:30:00 AM	0
10/3/2025	12:45:00 AM	0
10/3/2025	1:00:00 AM	0
10/3/2025	1:15:00 AM	0
10/3/2025	1:30:00 AM	0
10/3/2025	1:45:00 AM	0
10/3/2025	2:00:00 AM	0
10/3/2025	2:15:00 AM	0
10/3/2025	2:30:00 AM	0
10/3/2025	2:45:00 AM	0
10/3/2025	3:00:00 AM	0
10/3/2025	3:15:00 AM	0
10/3/2025	3:30:00 AM	0
10/3/2025	3:45:00 AM	0
10/3/2025	4:00:00 AM	0
10/3/2025	4:15:00 AM	0
10/3/2025	4:30:00 AM	0
10/3/2025	4:45:00 AM	0
10/3/2025	5:00:00 AM	0
10/3/2025	5:15:00 AM	0
10/3/2025	5:30:00 AM	0
10/3/2025	5:45:00 AM	0
10/3/2025	6:00:00 AM	0
10/3/2025	6:15:00 AM	0
10/3/2025	6:30:00 AM	0
10/3/2025	6:45:00 AM	0
10/3/2025	7:00:00 AM	0
10/3/2025	7:15:00 AM	0
10/3/2025	7:30:00 AM	0
10/3/2025	7:45:00 AM	0
10/3/2025	8:00:00 AM	0
10/3/2025	8:15:00 AM	0
10/3/2025	8:30:00 AM	0
10/3/2025	8:45:00 AM	0
10/3/2025	9:00:00 AM	0
10/3/2025	9:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/3/2025	9:30:00 AM	0
10/3/2025	9:45:00 AM	0
10/3/2025	10:00:00 AM	0
10/3/2025	10:15:00 AM	0
10/3/2025	10:30:00 AM	0
10/3/2025	10:45:00 AM	0
10/3/2025	11:00:00 AM	0
10/3/2025	11:15:00 AM	0
10/3/2025	11:30:00 AM	0
10/3/2025	11:45:00 AM	0
10/3/2025	12:00:00 PM	0
10/3/2025	12:15:00 PM	0
10/3/2025	12:30:00 PM	0
10/3/2025	12:45:00 PM	0
10/3/2025	1:00:00 PM	0
10/3/2025	1:15:00 PM	0
10/3/2025	1:30:00 PM	0
10/3/2025	1:45:00 PM	0
10/3/2025	2:00:00 PM	0
10/3/2025	2:15:00 PM	0
10/3/2025	2:30:00 PM	0
10/3/2025	2:45:00 PM	0
10/3/2025	3:00:00 PM	0
10/3/2025	3:15:00 PM	0
10/3/2025	3:30:00 PM	0
10/3/2025	3:45:00 PM	0
10/3/2025	4:00:00 PM	0
10/3/2025	4:15:00 PM	0
10/3/2025	4:30:00 PM	0
10/3/2025	4:45:00 PM	0
10/3/2025	5:00:00 PM	0
10/3/2025	5:15:00 PM	0
10/3/2025	5:30:00 PM	0
10/3/2025	5:45:00 PM	0
10/3/2025	6:00:00 PM	0
10/3/2025	6:15:00 PM	0
10/3/2025	6:30:00 PM	0
10/3/2025	6:45:00 PM	0
10/3/2025	7:00:00 PM	0
10/3/2025	7:15:00 PM	0
10/3/2025	7:30:00 PM	0
10/3/2025	7:45:00 PM	0
10/3/2025	8:00:00 PM	0
10/3/2025	8:15:00 PM	0
10/3/2025	8:30:00 PM	0
10/3/2025	8:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/3/2025	9:00:00 PM	0
10/3/2025	9:15:00 PM	0
10/3/2025	9:30:00 PM	0
10/3/2025	9:45:00 PM	0
10/3/2025	10:00:00 PM	0
10/3/2025	10:15:00 PM	0
10/3/2025	10:30:00 PM	0
10/3/2025	10:45:00 PM	0
10/3/2025	11:00:00 PM	0
10/3/2025	11:15:00 PM	0
10/3/2025	11:30:00 PM	0
10/3/2025	11:45:00 PM	0
10/4/2025	12:00:00 AM	0
10/4/2025	12:15:00 AM	0
10/4/2025	12:30:00 AM	0
10/4/2025	12:45:00 AM	0
10/4/2025	1:00:00 AM	0
10/4/2025	1:15:00 AM	0
10/4/2025	1:30:00 AM	0
10/4/2025	1:45:00 AM	0
10/4/2025	2:00:00 AM	0
10/4/2025	2:15:00 AM	0
10/4/2025	2:30:00 AM	0
10/4/2025	2:45:00 AM	0
10/4/2025	3:00:00 AM	0
10/4/2025	3:15:00 AM	0
10/4/2025	3:30:00 AM	0
10/4/2025	3:45:00 AM	0
10/4/2025	4:00:00 AM	0
10/4/2025	4:15:00 AM	0
10/4/2025	4:30:00 AM	0
10/4/2025	4:45:00 AM	0
10/4/2025	5:00:00 AM	0
10/4/2025	5:15:00 AM	0
10/4/2025	5:30:00 AM	0
10/4/2025	5:45:00 AM	0
10/4/2025	6:00:00 AM	0
10/4/2025	6:15:00 AM	0
10/4/2025	6:30:00 AM	0
10/4/2025	6:45:00 AM	0
10/4/2025	7:00:00 AM	0
10/4/2025	7:15:00 AM	0
10/4/2025	7:30:00 AM	0
10/4/2025	7:45:00 AM	0
10/4/2025	8:00:00 AM	0
10/4/2025	8:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/4/2025	8:30:00 AM	0
10/4/2025	8:45:00 AM	0
10/4/2025	9:00:00 AM	0
10/4/2025	9:15:00 AM	0
10/4/2025	9:30:00 AM	0
10/4/2025	9:45:00 AM	0
10/4/2025	10:00:00 AM	0
10/4/2025	10:15:00 AM	0
10/4/2025	10:30:00 AM	0
10/4/2025	10:45:00 AM	0
10/4/2025	11:00:00 AM	0
10/4/2025	11:15:00 AM	0
10/4/2025	11:30:00 AM	0
10/4/2025	11:45:00 AM	0
10/4/2025	12:00:00 PM	0
10/4/2025	12:15:00 PM	0
10/4/2025	12:30:00 PM	0
10/4/2025	12:45:00 PM	0
10/4/2025	1:00:00 PM	0
10/4/2025	1:15:00 PM	0
10/4/2025	1:30:00 PM	0
10/4/2025	1:45:00 PM	0
10/4/2025	2:00:00 PM	0
10/4/2025	2:15:00 PM	0
10/4/2025	2:30:00 PM	0
10/4/2025	2:45:00 PM	0
10/4/2025	3:00:00 PM	0
10/4/2025	3:15:00 PM	0
10/4/2025	3:30:00 PM	0
10/4/2025	3:45:00 PM	0
10/4/2025	4:00:00 PM	0
10/4/2025	4:15:00 PM	0
10/4/2025	4:30:00 PM	0
10/4/2025	4:45:00 PM	0
10/4/2025	5:00:00 PM	0
10/4/2025	5:15:00 PM	0
10/4/2025	5:30:00 PM	0
10/4/2025	5:45:00 PM	0
10/4/2025	6:00:00 PM	0
10/4/2025	6:15:00 PM	0
10/4/2025	6:30:00 PM	0
10/4/2025	6:45:00 PM	0
10/4/2025	7:00:00 PM	0
10/4/2025	7:15:00 PM	0
10/4/2025	7:30:00 PM	0
10/4/2025	7:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/4/2025	8:00:00 PM	0
10/4/2025	8:15:00 PM	0
10/4/2025	8:30:00 PM	0
10/4/2025	8:45:00 PM	0
10/4/2025	9:00:00 PM	0
10/4/2025	9:15:00 PM	0
10/4/2025	9:30:00 PM	0
10/4/2025	9:45:00 PM	0
10/4/2025	10:00:00 PM	0
10/4/2025	10:15:00 PM	0
10/4/2025	10:30:00 PM	0
10/4/2025	10:45:00 PM	0
10/4/2025	11:00:00 PM	0
10/4/2025	11:15:00 PM	0
10/4/2025	11:30:00 PM	0
10/4/2025	11:45:00 PM	0
10/5/2025	12:00:00 AM	0
10/5/2025	12:15:00 AM	0
10/5/2025	12:30:00 AM	0
10/5/2025	12:45:00 AM	0
10/5/2025	1:00:00 AM	0
10/5/2025	1:15:00 AM	0
10/5/2025	1:30:00 AM	0
10/5/2025	1:45:00 AM	0
10/5/2025	2:00:00 AM	0
10/5/2025	2:15:00 AM	0
10/5/2025	2:30:00 AM	0
10/5/2025	2:45:00 AM	0
10/5/2025	3:00:00 AM	0
10/5/2025	3:15:00 AM	0
10/5/2025	3:30:00 AM	0
10/5/2025	3:45:00 AM	0
10/5/2025	4:00:00 AM	0
10/5/2025	4:15:00 AM	0
10/5/2025	4:30:00 AM	0
10/5/2025	4:45:00 AM	0
10/5/2025	5:00:00 AM	0
10/5/2025	5:15:00 AM	0
10/5/2025	5:30:00 AM	0
10/5/2025	5:45:00 AM	0
10/5/2025	6:00:00 AM	0
10/5/2025	6:15:00 AM	0
10/5/2025	6:30:00 AM	0
10/5/2025	6:45:00 AM	0
10/5/2025	7:00:00 AM	0
10/5/2025	7:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/5/2025	7:30:00 AM	0
10/5/2025	7:45:00 AM	0
10/5/2025	8:00:00 AM	0
10/5/2025	8:15:00 AM	0
10/5/2025	8:30:00 AM	0
10/5/2025	8:45:00 AM	0
10/5/2025	9:00:00 AM	0
10/5/2025	9:15:00 AM	0
10/5/2025	9:30:00 AM	0
10/5/2025	9:45:00 AM	0
10/5/2025	10:00:00 AM	0
10/5/2025	10:15:00 AM	0
10/5/2025	10:30:00 AM	0
10/5/2025	10:45:00 AM	0
10/5/2025	11:00:00 AM	0
10/5/2025	11:15:00 AM	0
10/5/2025	11:30:00 AM	0
10/5/2025	11:45:00 AM	0
10/5/2025	12:00:00 PM	0
10/5/2025	12:15:00 PM	0
10/5/2025	12:30:00 PM	0
10/5/2025	12:45:00 PM	0
10/5/2025	1:00:00 PM	0
10/5/2025	1:15:00 PM	0
10/5/2025	1:30:00 PM	0
10/5/2025	1:45:00 PM	0
10/5/2025	2:00:00 PM	0
10/5/2025	2:15:00 PM	0
10/5/2025	2:30:00 PM	0
10/5/2025	2:45:00 PM	0
10/5/2025	3:00:00 PM	0
10/5/2025	3:15:00 PM	0
10/5/2025	3:30:00 PM	0
10/5/2025	3:45:00 PM	0
10/5/2025	4:00:00 PM	0
10/5/2025	4:15:00 PM	0
10/5/2025	4:30:00 PM	0
10/5/2025	4:45:00 PM	0
10/5/2025	5:00:00 PM	0
10/5/2025	5:15:00 PM	0
10/5/2025	5:30:00 PM	0
10/5/2025	5:45:00 PM	0
10/5/2025	6:00:00 PM	0
10/5/2025	6:15:00 PM	0
10/5/2025	6:30:00 PM	0
10/5/2025	6:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/5/2025	7:00:00 PM	0
10/5/2025	7:15:00 PM	0
10/5/2025	7:30:00 PM	0
10/5/2025	7:45:00 PM	0
10/5/2025	8:00:00 PM	0
10/5/2025	8:15:00 PM	0
10/5/2025	8:30:00 PM	0
10/5/2025	8:45:00 PM	0
10/5/2025	9:00:00 PM	0
10/5/2025	9:15:00 PM	0
10/5/2025	9:30:00 PM	0
10/5/2025	9:45:00 PM	0
10/5/2025	10:00:00 PM	0
10/5/2025	10:15:00 PM	0
10/5/2025	10:30:00 PM	0
10/5/2025	10:45:00 PM	0
10/5/2025	11:00:00 PM	0
10/5/2025	11:15:00 PM	0
10/5/2025	11:30:00 PM	0
10/5/2025	11:45:00 PM	0
10/6/2025	12:00:00 AM	0
10/6/2025	12:15:00 AM	0
10/6/2025	12:30:00 AM	0
10/6/2025	12:45:00 AM	0
10/6/2025	1:00:00 AM	0
10/6/2025	1:15:00 AM	0
10/6/2025	1:30:00 AM	0
10/6/2025	1:45:00 AM	0
10/6/2025	2:00:00 AM	0
10/6/2025	2:15:00 AM	0
10/6/2025	2:30:00 AM	0
10/6/2025	2:45:00 AM	0
10/6/2025	3:00:00 AM	0
10/6/2025	3:15:00 AM	0
10/6/2025	3:30:00 AM	0
10/6/2025	3:45:00 AM	0
10/6/2025	4:00:00 AM	0
10/6/2025	4:15:00 AM	0
10/6/2025	4:30:00 AM	0
10/6/2025	4:45:00 AM	0
10/6/2025	5:00:00 AM	0
10/6/2025	5:15:00 AM	0
10/6/2025	5:30:00 AM	0
10/6/2025	5:45:00 AM	0
10/6/2025	6:00:00 AM	0
10/6/2025	6:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/6/2025	6:30:00 AM	0
10/6/2025	6:45:00 AM	0
10/6/2025	7:00:00 AM	0
10/6/2025	7:15:00 AM	0
10/6/2025	7:30:00 AM	0
10/6/2025	7:45:00 AM	0
10/6/2025	8:00:00 AM	0
10/6/2025	8:15:00 AM	0
10/6/2025	8:30:00 AM	0
10/6/2025	8:45:00 AM	0
10/6/2025	9:00:00 AM	0
10/6/2025	9:15:00 AM	0
10/6/2025	9:30:00 AM	0
10/6/2025	9:45:00 AM	0
10/6/2025	10:00:00 AM	0
10/6/2025	10:15:00 AM	0
10/6/2025	10:30:00 AM	0
10/6/2025	10:45:00 AM	0
10/6/2025	11:00:00 AM	0
10/6/2025	11:15:00 AM	0
10/6/2025	11:30:00 AM	0
10/6/2025	11:45:00 AM	0
10/6/2025	12:00:00 PM	0
10/6/2025	12:15:00 PM	0
10/6/2025	12:30:00 PM	0
10/6/2025	12:45:00 PM	0
10/6/2025	1:00:00 PM	0
10/6/2025	1:15:00 PM	0
10/6/2025	1:30:00 PM	0
10/6/2025	1:45:00 PM	0
10/6/2025	2:00:00 PM	0
10/6/2025	2:15:00 PM	0
10/6/2025	2:30:00 PM	0
10/6/2025	2:45:00 PM	0
10/6/2025	3:00:00 PM	0
10/6/2025	3:15:00 PM	0
10/6/2025	3:30:00 PM	0
10/6/2025	3:45:00 PM	0
10/6/2025	4:00:00 PM	0
10/6/2025	4:15:00 PM	0
10/6/2025	4:30:00 PM	0
10/6/2025	4:45:00 PM	0
10/6/2025	5:00:00 PM	0
10/6/2025	5:15:00 PM	0
10/6/2025	5:30:00 PM	0
10/6/2025	5:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/6/2025	6:00:00 PM	0
10/6/2025	6:15:00 PM	0
10/6/2025	6:30:00 PM	0
10/6/2025	6:45:00 PM	0
10/6/2025	7:00:00 PM	0
10/6/2025	7:15:00 PM	0
10/6/2025	7:30:00 PM	0
10/6/2025	7:45:00 PM	0
10/6/2025	8:00:00 PM	0
10/6/2025	8:15:00 PM	0
10/6/2025	8:30:00 PM	0
10/6/2025	8:45:00 PM	0
10/6/2025	9:00:00 PM	0
10/6/2025	9:15:00 PM	0
10/6/2025	9:30:00 PM	0
10/6/2025	9:45:00 PM	0
10/6/2025	10:00:00 PM	0
10/6/2025	10:15:00 PM	0
10/6/2025	10:30:00 PM	0
10/6/2025	10:45:00 PM	0
10/6/2025	11:00:00 PM	0
10/6/2025	11:15:00 PM	0
10/6/2025	11:30:00 PM	0
10/6/2025	11:45:00 PM	0
10/7/2025	12:00:00 AM	0
10/7/2025	12:15:00 AM	0
10/7/2025	12:30:00 AM	0
10/7/2025	12:45:00 AM	0
10/7/2025	1:00:00 AM	0
10/7/2025	1:15:00 AM	0
10/7/2025	1:30:00 AM	0
10/7/2025	1:45:00 AM	0
10/7/2025	2:00:00 AM	0
10/7/2025	2:15:00 AM	0
10/7/2025	2:30:00 AM	0
10/7/2025	2:45:00 AM	0
10/7/2025	3:00:00 AM	0
10/7/2025	3:15:00 AM	0
10/7/2025	3:30:00 AM	0
10/7/2025	3:45:00 AM	0
10/7/2025	4:00:00 AM	0
10/7/2025	4:15:00 AM	0
10/7/2025	4:30:00 AM	0
10/7/2025	4:45:00 AM	0
10/7/2025	5:00:00 AM	0
10/7/2025	5:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/7/2025	5:30:00 AM	0
10/7/2025	5:45:00 AM	0
10/7/2025	6:00:00 AM	0
10/7/2025	6:15:00 AM	0
10/7/2025	6:30:00 AM	0
10/7/2025	6:45:00 AM	0
10/7/2025	7:00:00 AM	0
10/7/2025	7:15:00 AM	0
10/7/2025	7:30:00 AM	0
10/7/2025	7:45:00 AM	0
10/7/2025	8:00:00 AM	0
10/7/2025	8:15:00 AM	0
10/7/2025	8:30:00 AM	0
10/7/2025	8:45:00 AM	0
10/7/2025	9:00:00 AM	0
10/7/2025	9:15:00 AM	0
10/7/2025	9:30:00 AM	0
10/7/2025	9:45:00 AM	0
10/7/2025	10:00:00 AM	0
10/7/2025	10:15:00 AM	0
10/7/2025	10:30:00 AM	0
10/7/2025	10:45:00 AM	0
10/7/2025	11:00:00 AM	0
10/7/2025	11:15:00 AM	0
10/7/2025	11:30:00 AM	0
10/7/2025	11:45:00 AM	0
10/7/2025	12:00:00 PM	0
10/7/2025	12:15:00 PM	0
10/7/2025	12:30:00 PM	0
10/7/2025	12:45:00 PM	0
10/7/2025	1:00:00 PM	0
10/7/2025	1:15:00 PM	0
10/7/2025	1:30:00 PM	0
10/7/2025	1:45:00 PM	0
10/7/2025	2:00:00 PM	0
10/7/2025	2:15:00 PM	0
10/7/2025	2:30:00 PM	0
10/7/2025	2:45:00 PM	0
10/7/2025	3:00:00 PM	0
10/7/2025	3:15:00 PM	0
10/7/2025	3:30:00 PM	0
10/7/2025	3:45:00 PM	0
10/7/2025	4:00:00 PM	0
10/7/2025	4:15:00 PM	0
10/7/2025	4:30:00 PM	0
10/7/2025	4:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/7/2025	5:00:00 PM	0
10/7/2025	5:15:00 PM	0
10/7/2025	5:30:00 PM	0
10/7/2025	5:45:00 PM	0
10/7/2025	6:00:00 PM	0
10/7/2025	6:15:00 PM	0
10/7/2025	6:30:00 PM	0
10/7/2025	6:45:00 PM	0
10/7/2025	7:00:00 PM	0
10/7/2025	7:15:00 PM	0
10/7/2025	7:30:00 PM	0
10/7/2025	7:45:00 PM	0
10/7/2025	8:00:00 PM	0
10/7/2025	8:15:00 PM	0
10/7/2025	8:30:00 PM	0
10/7/2025	8:45:00 PM	0
10/7/2025	9:00:00 PM	0
10/7/2025	9:15:00 PM	0
10/7/2025	9:30:00 PM	0
10/7/2025	9:45:00 PM	0
10/7/2025	10:00:00 PM	0
10/7/2025	10:15:00 PM	0
10/7/2025	10:30:00 PM	0
10/7/2025	10:45:00 PM	0
10/7/2025	11:00:00 PM	0
10/7/2025	11:15:00 PM	0
10/7/2025	11:30:00 PM	0
10/7/2025	11:45:00 PM	0
10/8/2025	12:00:00 AM	0
10/8/2025	12:15:00 AM	0
10/8/2025	12:30:00 AM	0
10/8/2025	12:45:00 AM	0
10/8/2025	1:00:00 AM	0
10/8/2025	1:15:00 AM	0
10/8/2025	1:30:00 AM	0
10/8/2025	1:45:00 AM	0
10/8/2025	2:00:00 AM	0
10/8/2025	2:15:00 AM	0
10/8/2025	2:30:00 AM	0
10/8/2025	2:45:00 AM	0
10/8/2025	3:00:00 AM	0
10/8/2025	3:15:00 AM	0
10/8/2025	3:30:00 AM	0
10/8/2025	3:45:00 AM	0
10/8/2025	4:00:00 AM	0
10/8/2025	4:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/8/2025	4:30:00 AM	0
10/8/2025	4:45:00 AM	0
10/8/2025	5:00:00 AM	0
10/8/2025	5:15:00 AM	0
10/8/2025	5:30:00 AM	0
10/8/2025	5:45:00 AM	0
10/8/2025	6:00:00 AM	0
10/8/2025	6:15:00 AM	0
10/8/2025	6:30:00 AM	.
10/8/2025	6:45:00 AM	.
10/8/2025	7:00:00 AM	.
10/8/2025	7:15:00 AM	.
10/8/2025	7:30:00 AM	0
10/8/2025	7:45:00 AM	0
10/8/2025	8:00:00 AM	0
10/8/2025	8:15:00 AM	0
10/8/2025	8:30:00 AM	0
10/8/2025	8:45:00 AM	0
10/8/2025	9:00:00 AM	0
10/8/2025	9:15:00 AM	0
10/8/2025	9:30:00 AM	0
10/8/2025	9:45:00 AM	0
10/8/2025	10:00:00 AM	0
10/8/2025	10:15:00 AM	0
10/8/2025	10:30:00 AM	0
10/8/2025	10:45:00 AM	0
10/8/2025	11:00:00 AM	0
10/8/2025	11:15:00 AM	0
10/8/2025	11:30:00 AM	0
10/8/2025	11:45:00 AM	0
10/8/2025	12:00:00 PM	0
10/8/2025	12:15:00 PM	0
10/8/2025	12:30:00 PM	0
10/8/2025	12:45:00 PM	0
10/8/2025	1:00:00 PM	0
10/8/2025	1:15:00 PM	0
10/8/2025	1:30:00 PM	0
10/8/2025	1:45:00 PM	0
10/8/2025	2:00:00 PM	0
10/8/2025	2:15:00 PM	0
10/8/2025	2:30:00 PM	0
10/8/2025	2:45:00 PM	0
10/8/2025	3:00:00 PM	0
10/8/2025	3:15:00 PM	0
10/8/2025	3:30:00 PM	0
10/8/2025	3:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/8/2025	4:00:00 PM	0
10/8/2025	4:15:00 PM	0
10/8/2025	4:30:00 PM	0
10/8/2025	4:45:00 PM	0
10/8/2025	5:00:00 PM	0
10/8/2025	5:15:00 PM	0
10/8/2025	5:30:00 PM	0
10/8/2025	5:45:00 PM	0
10/8/2025	6:00:00 PM	0
10/8/2025	6:15:00 PM	0
10/8/2025	6:30:00 PM	0
10/8/2025	6:45:00 PM	0
10/8/2025	7:00:00 PM	0
10/8/2025	7:15:00 PM	0
10/8/2025	7:30:00 PM	0
10/8/2025	7:45:00 PM	0
10/8/2025	8:00:00 PM	0
10/8/2025	8:15:00 PM	0
10/8/2025	8:30:00 PM	0
10/8/2025	8:45:00 PM	0
10/8/2025	9:00:00 PM	0
10/8/2025	9:15:00 PM	0
10/8/2025	9:30:00 PM	0
10/8/2025	9:45:00 PM	0
10/8/2025	10:00:00 PM	0
10/8/2025	10:15:00 PM	0
10/8/2025	10:30:00 PM	0
10/8/2025	10:45:00 PM	0
10/8/2025	11:00:00 PM	0
10/8/2025	11:15:00 PM	0
10/8/2025	11:30:00 PM	0
10/8/2025	11:45:00 PM	0
10/9/2025	12:00:00 AM	0
10/9/2025	12:15:00 AM	0
10/9/2025	12:30:00 AM	0
10/9/2025	12:45:00 AM	0
10/9/2025	1:00:00 AM	0
10/9/2025	1:15:00 AM	0
10/9/2025	1:30:00 AM	0
10/9/2025	1:45:00 AM	0
10/9/2025	2:00:00 AM	0
10/9/2025	2:15:00 AM	0
10/9/2025	2:30:00 AM	0
10/9/2025	2:45:00 AM	0
10/9/2025	3:00:00 AM	0
10/9/2025	3:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/9/2025	3:30:00 AM	0
10/9/2025	3:45:00 AM	0
10/9/2025	4:00:00 AM	0
10/9/2025	4:15:00 AM	0
10/9/2025	4:30:00 AM	0
10/9/2025	4:45:00 AM	0
10/9/2025	5:00:00 AM	0
10/9/2025	5:15:00 AM	0
10/9/2025	5:30:00 AM	0
10/9/2025	5:45:00 AM	0
10/9/2025	6:00:00 AM	0
10/9/2025	6:15:00 AM	0
10/9/2025	6:30:00 AM	0
10/9/2025	6:45:00 AM	0
10/9/2025	7:00:00 AM	0
10/9/2025	7:15:00 AM	0
10/9/2025	7:30:00 AM	0
10/9/2025	7:45:00 AM	0
10/9/2025	8:00:00 AM	0
10/9/2025	8:15:00 AM	0
10/9/2025	8:30:00 AM	0
10/9/2025	8:45:00 AM	0
10/9/2025	9:00:00 AM	0
10/9/2025	9:15:00 AM	0
10/9/2025	9:30:00 AM	0
10/9/2025	9:45:00 AM	0
10/9/2025	10:00:00 AM	0
10/9/2025	10:15:00 AM	0
10/9/2025	10:30:00 AM	0
10/9/2025	10:45:00 AM	0
10/9/2025	11:00:00 AM	0
10/9/2025	11:15:00 AM	0
10/9/2025	11:30:00 AM	0
10/9/2025	11:45:00 AM	0
10/9/2025	12:00:00 PM	0
10/9/2025	12:15:00 PM	0
10/9/2025	12:30:00 PM	0
10/9/2025	12:45:00 PM	0
10/9/2025	1:00:00 PM	0
10/9/2025	1:15:00 PM	0
10/9/2025	1:30:00 PM	0
10/9/2025	1:45:00 PM	0
10/9/2025	2:00:00 PM	0
10/9/2025	2:15:00 PM	0
10/9/2025	2:30:00 PM	0
10/9/2025	2:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/9/2025	3:00:00 PM	0
10/9/2025	3:15:00 PM	0
10/9/2025	3:30:00 PM	0
10/9/2025	3:45:00 PM	0
10/9/2025	4:00:00 PM	0
10/9/2025	4:15:00 PM	0
10/9/2025	4:30:00 PM	0
10/9/2025	4:45:00 PM	0
10/9/2025	5:00:00 PM	0
10/9/2025	5:15:00 PM	0
10/9/2025	5:30:00 PM	0
10/9/2025	5:45:00 PM	0
10/9/2025	6:00:00 PM	0
10/9/2025	6:15:00 PM	0
10/9/2025	6:30:00 PM	0
10/9/2025	6:45:00 PM	0
10/9/2025	7:00:00 PM	0
10/9/2025	7:15:00 PM	0
10/9/2025	7:30:00 PM	0
10/9/2025	7:45:00 PM	0
10/9/2025	8:00:00 PM	0
10/9/2025	8:15:00 PM	0
10/9/2025	8:30:00 PM	0
10/9/2025	8:45:00 PM	0
10/9/2025	9:00:00 PM	0
10/9/2025	9:15:00 PM	0
10/9/2025	9:30:00 PM	0
10/9/2025	9:45:00 PM	0
10/9/2025	10:00:00 PM	0
10/9/2025	10:15:00 PM	0
10/9/2025	10:30:00 PM	0
10/9/2025	10:45:00 PM	0
10/9/2025	11:00:00 PM	0
10/9/2025	11:15:00 PM	0
10/9/2025	11:30:00 PM	0
10/9/2025	11:45:00 PM	0
10/10/2025	12:00:00 AM	0
10/10/2025	12:15:00 AM	0
10/10/2025	12:30:00 AM	0
10/10/2025	12:45:00 AM	0
10/10/2025	1:00:00 AM	0
10/10/2025	1:15:00 AM	0
10/10/2025	1:30:00 AM	0
10/10/2025	1:45:00 AM	0
10/10/2025	2:00:00 AM	0
10/10/2025	2:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/10/2025	2:30:00 AM	0
10/10/2025	2:45:00 AM	0
10/10/2025	3:00:00 AM	0
10/10/2025	3:15:00 AM	0
10/10/2025	3:30:00 AM	0
10/10/2025	3:45:00 AM	0
10/10/2025	4:00:00 AM	0
10/10/2025	4:15:00 AM	0
10/10/2025	4:30:00 AM	0
10/10/2025	4:45:00 AM	0
10/10/2025	5:00:00 AM	0
10/10/2025	5:15:00 AM	0
10/10/2025	5:30:00 AM	0
10/10/2025	5:45:00 AM	0
10/10/2025	6:00:00 AM	0
10/10/2025	6:15:00 AM	0
10/10/2025	6:30:00 AM	0
10/10/2025	6:45:00 AM	0
10/10/2025	7:00:00 AM	0
10/10/2025	7:15:00 AM	0
10/10/2025	7:30:00 AM	0
10/10/2025	7:45:00 AM	0
10/10/2025	8:00:00 AM	0
10/10/2025	8:15:00 AM	0
10/10/2025	8:30:00 AM	0
10/10/2025	8:45:00 AM	0
10/10/2025	9:00:00 AM	0
10/10/2025	9:15:00 AM	0
10/10/2025	9:30:00 AM	0
10/10/2025	9:45:00 AM	0
10/10/2025	10:00:00 AM	0
10/10/2025	10:15:00 AM	0
10/10/2025	10:30:00 AM	0
10/10/2025	10:45:00 AM	0
10/10/2025	11:00:00 AM	0
10/10/2025	11:15:00 AM	0
10/10/2025	11:30:00 AM	0
10/10/2025	11:45:00 AM	0
10/10/2025	12:00:00 PM	0
10/10/2025	12:15:00 PM	0
10/10/2025	12:30:00 PM	0
10/10/2025	12:45:00 PM	0
10/10/2025	1:00:00 PM	0
10/10/2025	1:15:00 PM	0
10/10/2025	1:30:00 PM	0
10/10/2025	1:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/10/2025	2:00:00 PM	0
10/10/2025	2:15:00 PM	0
10/10/2025	2:30:00 PM	0
10/10/2025	2:45:00 PM	0
10/10/2025	3:00:00 PM	0
10/10/2025	3:15:00 PM	0
10/10/2025	3:30:00 PM	0
10/10/2025	3:45:00 PM	0
10/10/2025	4:00:00 PM	0
10/10/2025	4:15:00 PM	0
10/10/2025	4:30:00 PM	0
10/10/2025	4:45:00 PM	0
10/10/2025	5:00:00 PM	0
10/10/2025	5:15:00 PM	0
10/10/2025	5:30:00 PM	0
10/10/2025	5:45:00 PM	0
10/10/2025	6:00:00 PM	0
10/10/2025	6:15:00 PM	0
10/10/2025	6:30:00 PM	0
10/10/2025	6:45:00 PM	0
10/10/2025	7:00:00 PM	0
10/10/2025	7:15:00 PM	0
10/10/2025	7:30:00 PM	0
10/10/2025	7:45:00 PM	0
10/10/2025	8:00:00 PM	0
10/10/2025	8:15:00 PM	0
10/10/2025	8:30:00 PM	0
10/10/2025	8:45:00 PM	0
10/10/2025	9:00:00 PM	0
10/10/2025	9:15:00 PM	0
10/10/2025	9:30:00 PM	0
10/10/2025	9:45:00 PM	0
10/10/2025	10:00:00 PM	0
10/10/2025	10:15:00 PM	0
10/10/2025	10:30:00 PM	0
10/10/2025	10:45:00 PM	0
10/10/2025	11:00:00 PM	0
10/10/2025	11:15:00 PM	0
10/10/2025	11:30:00 PM	0
10/10/2025	11:45:00 PM	0
10/11/2025	12:00:00 AM	0
10/11/2025	12:15:00 AM	0
10/11/2025	12:30:00 AM	0
10/11/2025	12:45:00 AM	0
10/11/2025	1:00:00 AM	0
10/11/2025	1:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/11/2025	1:30:00 AM	0
10/11/2025	1:45:00 AM	0
10/11/2025	2:00:00 AM	0
10/11/2025	2:15:00 AM	0
10/11/2025	2:30:00 AM	0
10/11/2025	2:45:00 AM	0
10/11/2025	3:00:00 AM	0
10/11/2025	3:15:00 AM	0
10/11/2025	3:30:00 AM	0
10/11/2025	3:45:00 AM	0
10/11/2025	4:00:00 AM	0
10/11/2025	4:15:00 AM	0
10/11/2025	4:30:00 AM	0
10/11/2025	4:45:00 AM	0
10/11/2025	5:00:00 AM	0
10/11/2025	5:15:00 AM	0
10/11/2025	5:30:00 AM	0
10/11/2025	5:45:00 AM	0
10/11/2025	6:00:00 AM	0
10/11/2025	6:15:00 AM	0
10/11/2025	6:30:00 AM	0
10/11/2025	6:45:00 AM	0
10/11/2025	7:00:00 AM	0
10/11/2025	7:15:00 AM	0
10/11/2025	7:30:00 AM	0
10/11/2025	7:45:00 AM	0
10/11/2025	8:00:00 AM	0
10/11/2025	8:15:00 AM	0
10/11/2025	8:30:00 AM	0
10/11/2025	8:45:00 AM	0
10/11/2025	9:00:00 AM	0
10/11/2025	9:15:00 AM	0
10/11/2025	9:30:00 AM	0
10/11/2025	9:45:00 AM	0
10/11/2025	10:00:00 AM	0
10/11/2025	10:15:00 AM	0
10/11/2025	10:30:00 AM	0
10/11/2025	10:45:00 AM	0
10/11/2025	11:00:00 AM	0
10/11/2025	11:15:00 AM	0
10/11/2025	11:30:00 AM	0
10/11/2025	11:45:00 AM	0
10/11/2025	12:00:00 PM	0
10/11/2025	12:15:00 PM	0
10/11/2025	12:30:00 PM	0
10/11/2025	12:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/11/2025	1:00:00 PM	0
10/11/2025	1:15:00 PM	0
10/11/2025	1:30:00 PM	0
10/11/2025	1:45:00 PM	0
10/11/2025	2:00:00 PM	0
10/11/2025	2:15:00 PM	0
10/11/2025	2:30:00 PM	0
10/11/2025	2:45:00 PM	0
10/11/2025	3:00:00 PM	0
10/11/2025	3:15:00 PM	0
10/11/2025	3:30:00 PM	0
10/11/2025	3:45:00 PM	0
10/11/2025	4:00:00 PM	0
10/11/2025	4:15:00 PM	0
10/11/2025	4:30:00 PM	0
10/11/2025	4:45:00 PM	0
10/11/2025	5:00:00 PM	0
10/11/2025	5:15:00 PM	0
10/11/2025	5:30:00 PM	0
10/11/2025	5:45:00 PM	0
10/11/2025	6:00:00 PM	0
10/11/2025	6:15:00 PM	0
10/11/2025	6:30:00 PM	0
10/11/2025	6:45:00 PM	0
10/11/2025	7:00:00 PM	0
10/11/2025	7:15:00 PM	0
10/11/2025	7:30:00 PM	0
10/11/2025	7:45:00 PM	0
10/11/2025	8:00:00 PM	0
10/11/2025	8:15:00 PM	0
10/11/2025	8:30:00 PM	0
10/11/2025	8:45:00 PM	0
10/11/2025	9:00:00 PM	0
10/11/2025	9:15:00 PM	0
10/11/2025	9:30:00 PM	0
10/11/2025	9:45:00 PM	0
10/11/2025	10:00:00 PM	0
10/11/2025	10:15:00 PM	0
10/11/2025	10:30:00 PM	0
10/11/2025	10:45:00 PM	0
10/11/2025	11:00:00 PM	0
10/11/2025	11:15:00 PM	0
10/11/2025	11:30:00 PM	0
10/11/2025	11:45:00 PM	0
10/12/2025	12:00:00 AM	0
10/12/2025	12:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/12/2025	12:30:00 AM	0
10/12/2025	12:45:00 AM	0
10/12/2025	1:00:00 AM	0
10/12/2025	1:15:00 AM	0
10/12/2025	1:30:00 AM	0
10/12/2025	1:45:00 AM	0
10/12/2025	2:00:00 AM	0
10/12/2025	2:15:00 AM	0
10/12/2025	2:30:00 AM	0
10/12/2025	2:45:00 AM	0
10/12/2025	3:00:00 AM	0
10/12/2025	3:15:00 AM	0
10/12/2025	3:30:00 AM	0
10/12/2025	3:45:00 AM	0
10/12/2025	4:00:00 AM	0
10/12/2025	4:15:00 AM	0
10/12/2025	4:30:00 AM	0
10/12/2025	4:45:00 AM	0
10/12/2025	5:00:00 AM	0
10/12/2025	5:15:00 AM	0
10/12/2025	5:30:00 AM	0
10/12/2025	5:45:00 AM	0
10/12/2025	6:00:00 AM	0
10/12/2025	6:15:00 AM	0
10/12/2025	6:30:00 AM	0
10/12/2025	6:45:00 AM	0
10/12/2025	7:00:00 AM	0
10/12/2025	7:15:00 AM	0
10/12/2025	7:30:00 AM	0
10/12/2025	7:45:00 AM	0
10/12/2025	8:00:00 AM	0
10/12/2025	8:15:00 AM	0
10/12/2025	8:30:00 AM	0
10/12/2025	8:45:00 AM	0
10/12/2025	9:00:00 AM	0
10/12/2025	9:15:00 AM	0
10/12/2025	9:30:00 AM	0
10/12/2025	9:45:00 AM	0
10/12/2025	10:00:00 AM	0
10/12/2025	10:15:00 AM	0
10/12/2025	10:30:00 AM	0
10/12/2025	10:45:00 AM	0
10/12/2025	11:00:00 AM	0
10/12/2025	11:15:00 AM	0
10/12/2025	11:30:00 AM	0
10/12/2025	11:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/12/2025	12:00:00 PM	0
10/12/2025	12:15:00 PM	0
10/12/2025	12:30:00 PM	0
10/12/2025	12:45:00 PM	0
10/12/2025	1:00:00 PM	0
10/12/2025	1:15:00 PM	0
10/12/2025	1:30:00 PM	0
10/12/2025	1:45:00 PM	0
10/12/2025	2:00:00 PM	0
10/12/2025	2:15:00 PM	0
10/12/2025	2:30:00 PM	0
10/12/2025	2:45:00 PM	0
10/12/2025	3:00:00 PM	0
10/12/2025	3:15:00 PM	0
10/12/2025	3:30:00 PM	0
10/12/2025	3:45:00 PM	0
10/12/2025	4:00:00 PM	0
10/12/2025	4:15:00 PM	0
10/12/2025	4:30:00 PM	0
10/12/2025	4:45:00 PM	0
10/12/2025	5:00:00 PM	0
10/12/2025	5:15:00 PM	0
10/12/2025	5:30:00 PM	0
10/12/2025	5:45:00 PM	0
10/12/2025	6:00:00 PM	0
10/12/2025	6:15:00 PM	0
10/12/2025	6:30:00 PM	0
10/12/2025	6:45:00 PM	0
10/12/2025	7:00:00 PM	0
10/12/2025	7:15:00 PM	0
10/12/2025	7:30:00 PM	0
10/12/2025	7:45:00 PM	0
10/12/2025	8:00:00 PM	0
10/12/2025	8:15:00 PM	0
10/12/2025	8:30:00 PM	0
10/12/2025	8:45:00 PM	0
10/12/2025	9:00:00 PM	0
10/12/2025	9:15:00 PM	0
10/12/2025	9:30:00 PM	0
10/12/2025	9:45:00 PM	0
10/12/2025	10:00:00 PM	0
10/12/2025	10:15:00 PM	0
10/12/2025	10:30:00 PM	0
10/12/2025	10:45:00 PM	0
10/12/2025	11:00:00 PM	0
10/12/2025	11:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/12/2025	11:30:00 PM	0
10/12/2025	11:45:00 PM	0
10/13/2025	12:00:00 AM	0
10/13/2025	12:15:00 AM	0
10/13/2025	12:30:00 AM	0
10/13/2025	12:45:00 AM	0
10/13/2025	1:00:00 AM	0
10/13/2025	1:15:00 AM	0
10/13/2025	1:30:00 AM	0
10/13/2025	1:45:00 AM	0
10/13/2025	2:00:00 AM	0
10/13/2025	2:15:00 AM	0
10/13/2025	2:30:00 AM	0
10/13/2025	2:45:00 AM	0
10/13/2025	3:00:00 AM	0
10/13/2025	3:15:00 AM	0
10/13/2025	3:30:00 AM	0
10/13/2025	3:45:00 AM	0
10/13/2025	4:00:00 AM	0
10/13/2025	4:15:00 AM	0
10/13/2025	4:30:00 AM	0
10/13/2025	4:45:00 AM	0
10/13/2025	5:00:00 AM	0
10/13/2025	5:15:00 AM	0
10/13/2025	5:30:00 AM	0
10/13/2025	5:45:00 AM	0
10/13/2025	6:00:00 AM	0
10/13/2025	6:15:00 AM	0
10/13/2025	6:30:00 AM	0
10/13/2025	6:45:00 AM	0
10/13/2025	7:00:00 AM	0
10/13/2025	7:15:00 AM	0
10/13/2025	7:30:00 AM	0
10/13/2025	7:45:00 AM	0
10/13/2025	8:00:00 AM	0
10/13/2025	8:15:00 AM	0
10/13/2025	8:30:00 AM	0
10/13/2025	8:45:00 AM	0
10/13/2025	9:00:00 AM	0
10/13/2025	9:15:00 AM	0
10/13/2025	9:30:00 AM	0
10/13/2025	9:45:00 AM	0
10/13/2025	10:00:00 AM	0
10/13/2025	10:15:00 AM	0
10/13/2025	10:30:00 AM	0
10/13/2025	10:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/13/2025	11:00:00 AM	0
10/13/2025	11:15:00 AM	0
10/13/2025	11:30:00 AM	0
10/13/2025	11:45:00 AM	0
10/13/2025	12:00:00 PM	0
10/13/2025	12:15:00 PM	0
10/13/2025	12:30:00 PM	0
10/13/2025	12:45:00 PM	0
10/13/2025	1:00:00 PM	0
10/13/2025	1:15:00 PM	0
10/13/2025	1:30:00 PM	0
10/13/2025	1:45:00 PM	0
10/13/2025	2:00:00 PM	0
10/13/2025	2:15:00 PM	0
10/13/2025	2:30:00 PM	0
10/13/2025	2:45:00 PM	0
10/13/2025	3:00:00 PM	0
10/13/2025	3:15:00 PM	0
10/13/2025	3:30:00 PM	0
10/13/2025	3:45:00 PM	0
10/13/2025	4:00:00 PM	0
10/13/2025	4:15:00 PM	0
10/13/2025	4:30:00 PM	0
10/13/2025	4:45:00 PM	0
10/13/2025	5:00:00 PM	0
10/13/2025	5:15:00 PM	0
10/13/2025	5:30:00 PM	0
10/13/2025	5:45:00 PM	0
10/13/2025	6:00:00 PM	0
10/13/2025	6:15:00 PM	0
10/13/2025	6:30:00 PM	0
10/13/2025	6:45:00 PM	0
10/13/2025	7:00:00 PM	0
10/13/2025	7:15:00 PM	0
10/13/2025	7:30:00 PM	0
10/13/2025	7:45:00 PM	0
10/13/2025	8:00:00 PM	0
10/13/2025	8:15:00 PM	0
10/13/2025	8:30:00 PM	0
10/13/2025	8:45:00 PM	0
10/13/2025	9:00:00 PM	0
10/13/2025	9:15:00 PM	0
10/13/2025	9:30:00 PM	0
10/13/2025	9:45:00 PM	0
10/13/2025	10:00:00 PM	0
10/13/2025	10:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/13/2025	10:30:00 PM	0
10/13/2025	10:45:00 PM	0
10/13/2025	11:00:00 PM	0
10/13/2025	11:15:00 PM	0
10/13/2025	11:30:00 PM	0
10/13/2025	11:45:00 PM	0
10/14/2025	12:00:00 AM	0
10/14/2025	12:15:00 AM	0
10/14/2025	12:30:00 AM	0
10/14/2025	12:45:00 AM	0
10/14/2025	1:00:00 AM	0
10/14/2025	1:15:00 AM	0
10/14/2025	1:30:00 AM	0
10/14/2025	1:45:00 AM	0
10/14/2025	2:00:00 AM	0
10/14/2025	2:15:00 AM	0
10/14/2025	2:30:00 AM	0
10/14/2025	2:45:00 AM	0
10/14/2025	3:00:00 AM	0
10/14/2025	3:15:00 AM	0
10/14/2025	3:30:00 AM	0
10/14/2025	3:45:00 AM	0
10/14/2025	4:00:00 AM	0
10/14/2025	4:15:00 AM	0
10/14/2025	4:30:00 AM	0
10/14/2025	4:45:00 AM	0
10/14/2025	5:00:00 AM	0
10/14/2025	5:15:00 AM	0
10/14/2025	5:30:00 AM	0
10/14/2025	5:45:00 AM	0
10/14/2025	6:00:00 AM	0
10/14/2025	6:15:00 AM	0
10/14/2025	6:30:00 AM	0
10/14/2025	6:45:00 AM	0
10/14/2025	7:00:00 AM	0
10/14/2025	7:15:00 AM	0
10/14/2025	7:30:00 AM	0
10/14/2025	7:45:00 AM	0
10/14/2025	8:00:00 AM	0
10/14/2025	8:15:00 AM	0
10/14/2025	8:30:00 AM	0
10/14/2025	8:45:00 AM	0
10/14/2025	9:00:00 AM	0
10/14/2025	9:15:00 AM	0
10/14/2025	9:30:00 AM	0
10/14/2025	9:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/14/2025	10:00:00 AM	0
10/14/2025	10:15:00 AM	0
10/14/2025	10:30:00 AM	0
10/14/2025	10:45:00 AM	0
10/14/2025	11:00:00 AM	0
10/14/2025	11:15:00 AM	0
10/14/2025	11:30:00 AM	0
10/14/2025	11:45:00 AM	0
10/14/2025	12:00:00 PM	0
10/14/2025	12:15:00 PM	0
10/14/2025	12:30:00 PM	0
10/14/2025	12:45:00 PM	0
10/14/2025	1:00:00 PM	0
10/14/2025	1:15:00 PM	0
10/14/2025	1:30:00 PM	0
10/14/2025	1:45:00 PM	0
10/14/2025	2:00:00 PM	0
10/14/2025	2:15:00 PM	0
10/14/2025	2:30:00 PM	0
10/14/2025	2:45:00 PM	0
10/14/2025	3:00:00 PM	0
10/14/2025	3:15:00 PM	0
10/14/2025	3:30:00 PM	0
10/14/2025	3:45:00 PM	0
10/14/2025	4:00:00 PM	0
10/14/2025	4:15:00 PM	0
10/14/2025	4:30:00 PM	0
10/14/2025	4:45:00 PM	0
10/14/2025	5:00:00 PM	0
10/14/2025	5:15:00 PM	0
10/14/2025	5:30:00 PM	0
10/14/2025	5:45:00 PM	0
10/14/2025	6:00:00 PM	0
10/14/2025	6:15:00 PM	0
10/14/2025	6:30:00 PM	0
10/14/2025	6:45:00 PM	0
10/14/2025	7:00:00 PM	0
10/14/2025	7:15:00 PM	0
10/14/2025	7:30:00 PM	0
10/14/2025	7:45:00 PM	0
10/14/2025	8:00:00 PM	0
10/14/2025	8:15:00 PM	0
10/14/2025	8:30:00 PM	0
10/14/2025	8:45:00 PM	0
10/14/2025	9:00:00 PM	0
10/14/2025	9:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/14/2025	9:30:00 PM	0
10/14/2025	9:45:00 PM	0
10/14/2025	10:00:00 PM	0
10/14/2025	10:15:00 PM	0
10/14/2025	10:30:00 PM	0
10/14/2025	10:45:00 PM	0
10/14/2025	11:00:00 PM	0
10/14/2025	11:15:00 PM	0
10/14/2025	11:30:00 PM	0
10/14/2025	11:45:00 PM	0
10/15/2025	12:00:00 AM	0
10/15/2025	12:15:00 AM	0
10/15/2025	12:30:00 AM	0
10/15/2025	12:45:00 AM	0
10/15/2025	1:00:00 AM	0
10/15/2025	1:15:00 AM	0
10/15/2025	1:30:00 AM	0
10/15/2025	1:45:00 AM	0
10/15/2025	2:00:00 AM	0
10/15/2025	2:15:00 AM	0
10/15/2025	2:30:00 AM	0
10/15/2025	2:45:00 AM	0
10/15/2025	3:00:00 AM	0
10/15/2025	3:15:00 AM	0
10/15/2025	3:30:00 AM	0
10/15/2025	3:45:00 AM	0
10/15/2025	4:00:00 AM	0
10/15/2025	4:15:00 AM	0
10/15/2025	4:30:00 AM	0
10/15/2025	4:45:00 AM	0
10/15/2025	5:00:00 AM	0
10/15/2025	5:15:00 AM	0
10/15/2025	5:30:00 AM	0
10/15/2025	5:45:00 AM	0
10/15/2025	6:00:00 AM	0
10/15/2025	6:15:00 AM	0
10/15/2025	6:30:00 AM	0
10/15/2025	6:45:00 AM	0
10/15/2025	7:00:00 AM	0
10/15/2025	7:15:00 AM	0
10/15/2025	7:30:00 AM	0
10/15/2025	7:45:00 AM	0
10/15/2025	8:00:00 AM	0
10/15/2025	8:15:00 AM	0
10/15/2025	8:30:00 AM	0
10/15/2025	8:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/15/2025	9:00:00 AM	0
10/15/2025	9:15:00 AM	0
10/15/2025	9:30:00 AM	0
10/15/2025	9:45:00 AM	0
10/15/2025	10:00:00 AM	0
10/15/2025	10:15:00 AM	0
10/15/2025	10:30:00 AM	0
10/15/2025	10:45:00 AM	0
10/15/2025	11:00:00 AM	0
10/15/2025	11:15:00 AM	0
10/15/2025	11:30:00 AM	0
10/15/2025	11:45:00 AM	0
10/15/2025	12:00:00 PM	0
10/15/2025	12:15:00 PM	0
10/15/2025	12:30:00 PM	0
10/15/2025	12:45:00 PM	0
10/15/2025	1:00:00 PM	0
10/15/2025	1:15:00 PM	0
10/15/2025	1:30:00 PM	0
10/15/2025	1:45:00 PM	0
10/15/2025	2:00:00 PM	0
10/15/2025	2:15:00 PM	0
10/15/2025	2:30:00 PM	0
10/15/2025	2:45:00 PM	0
10/15/2025	3:00:00 PM	0
10/15/2025	3:15:00 PM	0
10/15/2025	3:30:00 PM	0
10/15/2025	3:45:00 PM	0
10/15/2025	4:00:00 PM	0
10/15/2025	4:15:00 PM	0
10/15/2025	4:30:00 PM	0
10/15/2025	4:45:00 PM	0
10/15/2025	5:00:00 PM	0
10/15/2025	5:15:00 PM	0
10/15/2025	5:30:00 PM	0
10/15/2025	5:45:00 PM	0
10/15/2025	6:00:00 PM	0
10/15/2025	6:15:00 PM	0
10/15/2025	6:30:00 PM	0
10/15/2025	6:45:00 PM	0
10/15/2025	7:00:00 PM	0
10/15/2025	7:15:00 PM	0
10/15/2025	7:30:00 PM	0
10/15/2025	7:45:00 PM	0
10/15/2025	8:00:00 PM	0
10/15/2025	8:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/15/2025	8:30:00 PM	0
10/15/2025	8:45:00 PM	0
10/15/2025	9:00:00 PM	0
10/15/2025	9:15:00 PM	0
10/15/2025	9:30:00 PM	0
10/15/2025	9:45:00 PM	0
10/15/2025	10:00:00 PM	0
10/15/2025	10:15:00 PM	0
10/15/2025	10:30:00 PM	0
10/15/2025	10:45:00 PM	0
10/15/2025	11:00:00 PM	0
10/15/2025	11:15:00 PM	0
10/15/2025	11:30:00 PM	0
10/15/2025	11:45:00 PM	0
10/16/2025	12:00:00 AM	0
10/16/2025	12:15:00 AM	0
10/16/2025	12:30:00 AM	0
10/16/2025	12:45:00 AM	0
10/16/2025	1:00:00 AM	0
10/16/2025	1:15:00 AM	0
10/16/2025	1:30:00 AM	0
10/16/2025	1:45:00 AM	0
10/16/2025	2:00:00 AM	0
10/16/2025	2:15:00 AM	0
10/16/2025	2:30:00 AM	0
10/16/2025	2:45:00 AM	0
10/16/2025	3:00:00 AM	0
10/16/2025	3:15:00 AM	0
10/16/2025	3:30:00 AM	0
10/16/2025	3:45:00 AM	0
10/16/2025	4:00:00 AM	0
10/16/2025	4:15:00 AM	0
10/16/2025	4:30:00 AM	0
10/16/2025	4:45:00 AM	0
10/16/2025	5:00:00 AM	0
10/16/2025	5:15:00 AM	0
10/16/2025	5:30:00 AM	0
10/16/2025	5:45:00 AM	0
10/16/2025	6:00:00 AM	0
10/16/2025	6:15:00 AM	0
10/16/2025	6:30:00 AM	0
10/16/2025	6:45:00 AM	0
10/16/2025	7:00:00 AM	0
10/16/2025	7:15:00 AM	0
10/16/2025	7:30:00 AM	0
10/16/2025	7:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/16/2025	8:00:00 AM	0
10/16/2025	8:15:00 AM	0
10/16/2025	8:30:00 AM	0
10/16/2025	8:45:00 AM	0
10/16/2025	9:00:00 AM	0
10/16/2025	9:15:00 AM	0
10/16/2025	9:30:00 AM	0
10/16/2025	9:45:00 AM	0
10/16/2025	10:00:00 AM	0
10/16/2025	10:15:00 AM	0
10/16/2025	10:30:00 AM	0
10/16/2025	10:45:00 AM	0
10/16/2025	11:00:00 AM	0
10/16/2025	11:15:00 AM	0
10/16/2025	11:30:00 AM	0
10/16/2025	11:45:00 AM	0
10/16/2025	12:00:00 PM	0
10/16/2025	12:15:00 PM	0
10/16/2025	12:30:00 PM	0
10/16/2025	12:45:00 PM	0
10/16/2025	1:00:00 PM	0
10/16/2025	1:15:00 PM	0
10/16/2025	1:30:00 PM	0
10/16/2025	1:45:00 PM	0
10/16/2025	2:00:00 PM	0
10/16/2025	2:15:00 PM	0
10/16/2025	2:30:00 PM	0
10/16/2025	2:45:00 PM	0
10/16/2025	3:00:00 PM	0
10/16/2025	3:15:00 PM	0
10/16/2025	3:30:00 PM	0
10/16/2025	3:45:00 PM	0
10/16/2025	4:00:00 PM	0
10/16/2025	4:15:00 PM	0
10/16/2025	4:30:00 PM	0
10/16/2025	4:45:00 PM	0
10/16/2025	5:00:00 PM	0
10/16/2025	5:15:00 PM	0
10/16/2025	5:30:00 PM	0
10/16/2025	5:45:00 PM	0
10/16/2025	6:00:00 PM	0
10/16/2025	6:15:00 PM	0
10/16/2025	6:30:00 PM	0
10/16/2025	6:45:00 PM	0
10/16/2025	7:00:00 PM	0
10/16/2025	7:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/16/2025	7:30:00 PM	0
10/16/2025	7:45:00 PM	0
10/16/2025	8:00:00 PM	0
10/16/2025	8:15:00 PM	0
10/16/2025	8:30:00 PM	0
10/16/2025	8:45:00 PM	0
10/16/2025	9:00:00 PM	0
10/16/2025	9:15:00 PM	0
10/16/2025	9:30:00 PM	0
10/16/2025	9:45:00 PM	0
10/16/2025	10:00:00 PM	0
10/16/2025	10:15:00 PM	0
10/16/2025	10:30:00 PM	0
10/16/2025	10:45:00 PM	0
10/16/2025	11:00:00 PM	0
10/16/2025	11:15:00 PM	0
10/16/2025	11:30:00 PM	0
10/16/2025	11:45:00 PM	0
10/17/2025	12:00:00 AM	0
10/17/2025	12:15:00 AM	0
10/17/2025	12:30:00 AM	0
10/17/2025	12:45:00 AM	0
10/17/2025	1:00:00 AM	0
10/17/2025	1:15:00 AM	0
10/17/2025	1:30:00 AM	0
10/17/2025	1:45:00 AM	0
10/17/2025	2:00:00 AM	0
10/17/2025	2:15:00 AM	0
10/17/2025	2:30:00 AM	0
10/17/2025	2:45:00 AM	0
10/17/2025	3:00:00 AM	0
10/17/2025	3:15:00 AM	0
10/17/2025	3:30:00 AM	0
10/17/2025	3:45:00 AM	0
10/17/2025	4:00:00 AM	0
10/17/2025	4:15:00 AM	0
10/17/2025	4:30:00 AM	0
10/17/2025	4:45:00 AM	0
10/17/2025	5:00:00 AM	0
10/17/2025	5:15:00 AM	0
10/17/2025	5:30:00 AM	0
10/17/2025	5:45:00 AM	0
10/17/2025	6:00:00 AM	0
10/17/2025	6:15:00 AM	0
10/17/2025	6:30:00 AM	0
10/17/2025	6:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/17/2025	7:00:00 AM	0
10/17/2025	7:15:00 AM	0
10/17/2025	7:30:00 AM	0
10/17/2025	7:45:00 AM	0
10/17/2025	8:00:00 AM	0
10/17/2025	8:15:00 AM	0
10/17/2025	8:30:00 AM	0
10/17/2025	8:45:00 AM	0
10/17/2025	9:00:00 AM	0
10/17/2025	9:15:00 AM	0
10/17/2025	9:30:00 AM	0
10/17/2025	9:45:00 AM	0
10/17/2025	10:00:00 AM	0
10/17/2025	10:15:00 AM	0
10/17/2025	10:30:00 AM	0
10/17/2025	10:45:00 AM	0
10/17/2025	11:00:00 AM	0
10/17/2025	11:15:00 AM	0
10/17/2025	11:30:00 AM	0
10/17/2025	11:45:00 AM	0
10/17/2025	12:00:00 PM	0
10/17/2025	12:15:00 PM	0
10/17/2025	12:30:00 PM	0
10/17/2025	12:45:00 PM	0
10/17/2025	1:00:00 PM	0
10/17/2025	1:15:00 PM	0
10/17/2025	1:30:00 PM	0
10/17/2025	1:45:00 PM	0
10/17/2025	2:00:00 PM	0
10/17/2025	2:15:00 PM	0
10/17/2025	2:30:00 PM	0
10/17/2025	2:45:00 PM	0
10/17/2025	3:00:00 PM	0
10/17/2025	3:15:00 PM	0
10/17/2025	3:30:00 PM	0
10/17/2025	3:45:00 PM	0
10/17/2025	4:00:00 PM	0
10/17/2025	4:15:00 PM	0
10/17/2025	4:30:00 PM	0
10/17/2025	4:45:00 PM	0
10/17/2025	5:00:00 PM	0
10/17/2025	5:15:00 PM	0
10/17/2025	5:30:00 PM	0
10/17/2025	5:45:00 PM	0
10/17/2025	6:00:00 PM	0
10/17/2025	6:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/17/2025	6:30:00 PM	0
10/17/2025	6:45:00 PM	0
10/17/2025	7:00:00 PM	0
10/17/2025	7:15:00 PM	0
10/17/2025	7:30:00 PM	0
10/17/2025	7:45:00 PM	0
10/17/2025	8:00:00 PM	0
10/17/2025	8:15:00 PM	0
10/17/2025	8:30:00 PM	0
10/17/2025	8:45:00 PM	0
10/17/2025	9:00:00 PM	0
10/17/2025	9:15:00 PM	0
10/17/2025	9:30:00 PM	0
10/17/2025	9:45:00 PM	0
10/17/2025	10:00:00 PM	0
10/17/2025	10:15:00 PM	0
10/17/2025	10:30:00 PM	0
10/17/2025	10:45:00 PM	0
10/17/2025	11:00:00 PM	0
10/17/2025	11:15:00 PM	0
10/17/2025	11:30:00 PM	0
10/17/2025	11:45:00 PM	0
10/18/2025	12:00:00 AM	0
10/18/2025	12:15:00 AM	0
10/18/2025	12:30:00 AM	0
10/18/2025	12:45:00 AM	0
10/18/2025	1:00:00 AM	0
10/18/2025	1:15:00 AM	0
10/18/2025	1:30:00 AM	0
10/18/2025	1:45:00 AM	0
10/18/2025	2:00:00 AM	0
10/18/2025	2:15:00 AM	0
10/18/2025	2:30:00 AM	0
10/18/2025	2:45:00 AM	0
10/18/2025	3:00:00 AM	0
10/18/2025	3:15:00 AM	0
10/18/2025	3:30:00 AM	0
10/18/2025	3:45:00 AM	0
10/18/2025	4:00:00 AM	0
10/18/2025	4:15:00 AM	0
10/18/2025	4:30:00 AM	0
10/18/2025	4:45:00 AM	0
10/18/2025	5:00:00 AM	0
10/18/2025	5:15:00 AM	0
10/18/2025	5:30:00 AM	0
10/18/2025	5:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/18/2025	6:00:00 AM	0
10/18/2025	6:15:00 AM	0
10/18/2025	6:30:00 AM	0
10/18/2025	6:45:00 AM	0
10/18/2025	7:00:00 AM	0
10/18/2025	7:15:00 AM	0
10/18/2025	7:30:00 AM	0
10/18/2025	7:45:00 AM	0
10/18/2025	8:00:00 AM	0
10/18/2025	8:15:00 AM	0
10/18/2025	8:30:00 AM	0
10/18/2025	8:45:00 AM	0
10/18/2025	9:00:00 AM	0
10/18/2025	9:15:00 AM	0
10/18/2025	9:30:00 AM	0
10/18/2025	9:45:00 AM	0
10/18/2025	10:00:00 AM	0
10/18/2025	10:15:00 AM	0
10/18/2025	10:30:00 AM	0
10/18/2025	10:45:00 AM	0
10/18/2025	11:00:00 AM	0
10/18/2025	11:15:00 AM	0
10/18/2025	11:30:00 AM	0
10/18/2025	11:45:00 AM	0
10/18/2025	12:00:00 PM	0
10/18/2025	12:15:00 PM	0
10/18/2025	12:30:00 PM	0
10/18/2025	12:45:00 PM	0
10/18/2025	1:00:00 PM	0
10/18/2025	1:15:00 PM	0
10/18/2025	1:30:00 PM	0
10/18/2025	1:45:00 PM	0
10/18/2025	2:00:00 PM	0
10/18/2025	2:15:00 PM	0
10/18/2025	2:30:00 PM	0
10/18/2025	2:45:00 PM	0
10/18/2025	3:00:00 PM	0
10/18/2025	3:15:00 PM	0
10/18/2025	3:30:00 PM	0
10/18/2025	3:45:00 PM	0
10/18/2025	4:00:00 PM	0
10/18/2025	4:15:00 PM	0
10/18/2025	4:30:00 PM	0
10/18/2025	4:45:00 PM	0
10/18/2025	5:00:00 PM	0
10/18/2025	5:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/18/2025	5:30:00 PM	0
10/18/2025	5:45:00 PM	0
10/18/2025	6:00:00 PM	0
10/18/2025	6:15:00 PM	0
10/18/2025	6:30:00 PM	0
10/18/2025	6:45:00 PM	0
10/18/2025	7:00:00 PM	0
10/18/2025	7:15:00 PM	0
10/18/2025	7:30:00 PM	0
10/18/2025	7:45:00 PM	0
10/18/2025	8:00:00 PM	0
10/18/2025	8:15:00 PM	0
10/18/2025	8:30:00 PM	0
10/18/2025	8:45:00 PM	0
10/18/2025	9:00:00 PM	0
10/18/2025	9:15:00 PM	0
10/18/2025	9:30:00 PM	0
10/18/2025	9:45:00 PM	0
10/18/2025	10:00:00 PM	0
10/18/2025	10:15:00 PM	0
10/18/2025	10:30:00 PM	0
10/18/2025	10:45:00 PM	0
10/18/2025	11:00:00 PM	0
10/18/2025	11:15:00 PM	0
10/18/2025	11:30:00 PM	0
10/18/2025	11:45:00 PM	0
10/19/2025	12:00:00 AM	0
10/19/2025	12:15:00 AM	0
10/19/2025	12:30:00 AM	0
10/19/2025	12:45:00 AM	0
10/19/2025	1:00:00 AM	0
10/19/2025	1:15:00 AM	0
10/19/2025	1:30:00 AM	0
10/19/2025	1:45:00 AM	0
10/19/2025	2:00:00 AM	0
10/19/2025	2:15:00 AM	0
10/19/2025	2:30:00 AM	0
10/19/2025	2:45:00 AM	0
10/19/2025	3:00:00 AM	0
10/19/2025	3:15:00 AM	0
10/19/2025	3:30:00 AM	0
10/19/2025	3:45:00 AM	0
10/19/2025	4:00:00 AM	0
10/19/2025	4:15:00 AM	0
10/19/2025	4:30:00 AM	0
10/19/2025	4:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/19/2025	5:00:00 AM	0
10/19/2025	5:15:00 AM	0
10/19/2025	5:30:00 AM	0
10/19/2025	5:45:00 AM	0
10/19/2025	6:00:00 AM	0
10/19/2025	6:15:00 AM	0
10/19/2025	6:30:00 AM	0
10/19/2025	6:45:00 AM	0
10/19/2025	7:00:00 AM	0
10/19/2025	7:15:00 AM	0
10/19/2025	7:30:00 AM	0
10/19/2025	7:45:00 AM	0
10/19/2025	8:00:00 AM	0
10/19/2025	8:15:00 AM	0
10/19/2025	8:30:00 AM	0
10/19/2025	8:45:00 AM	0
10/19/2025	9:00:00 AM	0
10/19/2025	9:15:00 AM	0
10/19/2025	9:30:00 AM	0
10/19/2025	9:45:00 AM	0
10/19/2025	10:00:00 AM	0
10/19/2025	10:15:00 AM	0
10/19/2025	10:30:00 AM	0
10/19/2025	10:45:00 AM	0
10/19/2025	11:00:00 AM	0
10/19/2025	11:15:00 AM	0
10/19/2025	11:30:00 AM	0
10/19/2025	11:45:00 AM	0
10/19/2025	12:00:00 PM	0
10/19/2025	12:15:00 PM	0
10/19/2025	12:30:00 PM	0
10/19/2025	12:45:00 PM	0
10/19/2025	1:00:00 PM	0
10/19/2025	1:15:00 PM	0
10/19/2025	1:30:00 PM	0
10/19/2025	1:45:00 PM	0
10/19/2025	2:00:00 PM	0
10/19/2025	2:15:00 PM	0
10/19/2025	2:30:00 PM	0
10/19/2025	2:45:00 PM	0
10/19/2025	3:00:00 PM	0
10/19/2025	3:15:00 PM	0
10/19/2025	3:30:00 PM	0
10/19/2025	3:45:00 PM	0
10/19/2025	4:00:00 PM	0
10/19/2025	4:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/19/2025	4:30:00 PM	0
10/19/2025	4:45:00 PM	0
10/19/2025	5:00:00 PM	0
10/19/2025	5:15:00 PM	0
10/19/2025	5:30:00 PM	0
10/19/2025	5:45:00 PM	0
10/19/2025	6:00:00 PM	0
10/19/2025	6:15:00 PM	0
10/19/2025	6:30:00 PM	0
10/19/2025	6:45:00 PM	0
10/19/2025	7:00:00 PM	0
10/19/2025	7:15:00 PM	0
10/19/2025	7:30:00 PM	0
10/19/2025	7:45:00 PM	0
10/19/2025	8:00:00 PM	0
10/19/2025	8:15:00 PM	0
10/19/2025	8:30:00 PM	0
10/19/2025	8:45:00 PM	0
10/19/2025	9:00:00 PM	0
10/19/2025	9:15:00 PM	0
10/19/2025	9:30:00 PM	0
10/19/2025	9:45:00 PM	0
10/19/2025	10:00:00 PM	0
10/19/2025	10:15:00 PM	0
10/19/2025	10:30:00 PM	0
10/19/2025	10:45:00 PM	0
10/19/2025	11:00:00 PM	0
10/19/2025	11:15:00 PM	0
10/19/2025	11:30:00 PM	0
10/19/2025	11:45:00 PM	0
10/20/2025	12:00:00 AM	0
10/20/2025	12:15:00 AM	0
10/20/2025	12:30:00 AM	0
10/20/2025	12:45:00 AM	0
10/20/2025	1:00:00 AM	0
10/20/2025	1:15:00 AM	0
10/20/2025	1:30:00 AM	0
10/20/2025	1:45:00 AM	0
10/20/2025	2:00:00 AM	0
10/20/2025	2:15:00 AM	0
10/20/2025	2:30:00 AM	0
10/20/2025	2:45:00 AM	0
10/20/2025	3:00:00 AM	0
10/20/2025	3:15:00 AM	0
10/20/2025	3:30:00 AM	0
10/20/2025	3:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/20/2025	4:00:00 AM	0
10/20/2025	4:15:00 AM	0
10/20/2025	4:30:00 AM	0
10/20/2025	4:45:00 AM	0
10/20/2025	5:00:00 AM	0
10/20/2025	5:15:00 AM	0
10/20/2025	5:30:00 AM	0
10/20/2025	5:45:00 AM	0
10/20/2025	6:00:00 AM	0
10/20/2025	6:15:00 AM	0
10/20/2025	6:30:00 AM	0
10/20/2025	6:45:00 AM	0
10/20/2025	7:00:00 AM	0
10/20/2025	7:15:00 AM	0
10/20/2025	7:30:00 AM	0
10/20/2025	7:45:00 AM	0
10/20/2025	8:00:00 AM	0
10/20/2025	8:15:00 AM	0
10/20/2025	8:30:00 AM	0
10/20/2025	8:45:00 AM	0
10/20/2025	9:00:00 AM	0
10/20/2025	9:15:00 AM	0
10/20/2025	9:30:00 AM	0
10/20/2025	9:45:00 AM	0
10/20/2025	10:00:00 AM	0
10/20/2025	10:15:00 AM	0
10/20/2025	10:30:00 AM	0
10/20/2025	10:45:00 AM	0
10/20/2025	11:00:00 AM	0
10/20/2025	11:15:00 AM	0
10/20/2025	11:30:00 AM	0
10/20/2025	11:45:00 AM	0
10/20/2025	12:00:00 PM	0
10/20/2025	12:15:00 PM	0
10/20/2025	12:30:00 PM	0
10/20/2025	12:45:00 PM	0
10/20/2025	1:00:00 PM	0
10/20/2025	1:15:00 PM	0
10/20/2025	1:30:00 PM	0
10/20/2025	1:45:00 PM	0
10/20/2025	2:00:00 PM	0
10/20/2025	2:15:00 PM	0
10/20/2025	2:30:00 PM	0
10/20/2025	2:45:00 PM	0
10/20/2025	3:00:00 PM	0
10/20/2025	3:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/20/2025	3:30:00 PM	0
10/20/2025	3:45:00 PM	0
10/20/2025	4:00:00 PM	0
10/20/2025	4:15:00 PM	0
10/20/2025	4:30:00 PM	0
10/20/2025	4:45:00 PM	0
10/20/2025	5:00:00 PM	0
10/20/2025	5:15:00 PM	0
10/20/2025	5:30:00 PM	0
10/20/2025	5:45:00 PM	0
10/20/2025	6:00:00 PM	0
10/20/2025	6:15:00 PM	0
10/20/2025	6:30:00 PM	0
10/20/2025	6:45:00 PM	0
10/20/2025	7:00:00 PM	0
10/20/2025	7:15:00 PM	0
10/20/2025	7:30:00 PM	0
10/20/2025	7:45:00 PM	0
10/20/2025	8:00:00 PM	0
10/20/2025	8:15:00 PM	0
10/20/2025	8:30:00 PM	0
10/20/2025	8:45:00 PM	0
10/20/2025	9:00:00 PM	0
10/20/2025	9:15:00 PM	0
10/20/2025	9:30:00 PM	0
10/20/2025	9:45:00 PM	0
10/20/2025	10:00:00 PM	0
10/20/2025	10:15:00 PM	0
10/20/2025	10:30:00 PM	0
10/20/2025	10:45:00 PM	0
10/20/2025	11:00:00 PM	0
10/20/2025	11:15:00 PM	0
10/20/2025	11:30:00 PM	0
10/20/2025	11:45:00 PM	0
10/21/2025	12:00:00 AM	0
10/21/2025	12:15:00 AM	0
10/21/2025	12:30:00 AM	0
10/21/2025	12:45:00 AM	0
10/21/2025	1:00:00 AM	0
10/21/2025	1:15:00 AM	0
10/21/2025	1:30:00 AM	0
10/21/2025	1:45:00 AM	0
10/21/2025	2:00:00 AM	0
10/21/2025	2:15:00 AM	0
10/21/2025	2:30:00 AM	0
10/21/2025	2:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/21/2025	3:00:00 AM	0
10/21/2025	3:15:00 AM	0
10/21/2025	3:30:00 AM	0
10/21/2025	3:45:00 AM	0
10/21/2025	4:00:00 AM	0
10/21/2025	4:15:00 AM	0
10/21/2025	4:30:00 AM	0
10/21/2025	4:45:00 AM	0
10/21/2025	5:00:00 AM	0
10/21/2025	5:15:00 AM	0
10/21/2025	5:30:00 AM	0
10/21/2025	5:45:00 AM	0
10/21/2025	6:00:00 AM	0
10/21/2025	6:15:00 AM	0
10/21/2025	6:30:00 AM	0
10/21/2025	6:45:00 AM	0
10/21/2025	7:00:00 AM	0
10/21/2025	7:15:00 AM	0
10/21/2025	7:30:00 AM	0
10/21/2025	7:45:00 AM	0
10/21/2025	8:00:00 AM	0
10/21/2025	8:15:00 AM	0
10/21/2025	8:30:00 AM	0
10/21/2025	8:45:00 AM	0
10/21/2025	9:00:00 AM	0
10/21/2025	9:15:00 AM	0
10/21/2025	9:30:00 AM	0
10/21/2025	9:45:00 AM	0
10/21/2025	10:00:00 AM	0
10/21/2025	10:15:00 AM	0
10/21/2025	10:30:00 AM	0
10/21/2025	10:45:00 AM	0
10/21/2025	11:00:00 AM	0
10/21/2025	11:15:00 AM	0
10/21/2025	11:30:00 AM	0
10/21/2025	11:45:00 AM	0
10/21/2025	12:00:00 PM	0
10/21/2025	12:15:00 PM	0
10/21/2025	12:30:00 PM	0
10/21/2025	12:45:00 PM	0
10/21/2025	1:00:00 PM	0
10/21/2025	1:15:00 PM	0
10/21/2025	1:30:00 PM	0
10/21/2025	1:45:00 PM	0
10/21/2025	2:00:00 PM	0
10/21/2025	2:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/21/2025	2:30:00 PM	0
10/21/2025	2:45:00 PM	0
10/21/2025	3:00:00 PM	0
10/21/2025	3:15:00 PM	0
10/21/2025	3:30:00 PM	0
10/21/2025	3:45:00 PM	0
10/21/2025	4:00:00 PM	0
10/21/2025	4:15:00 PM	0
10/21/2025	4:30:00 PM	0
10/21/2025	4:45:00 PM	0
10/21/2025	5:00:00 PM	0
10/21/2025	5:15:00 PM	0
10/21/2025	5:30:00 PM	0
10/21/2025	5:45:00 PM	0
10/21/2025	6:00:00 PM	0
10/21/2025	6:15:00 PM	0
10/21/2025	6:30:00 PM	0
10/21/2025	6:45:00 PM	0
10/21/2025	7:00:00 PM	0
10/21/2025	7:15:00 PM	0
10/21/2025	7:30:00 PM	0
10/21/2025	7:45:00 PM	0
10/21/2025	8:00:00 PM	0
10/21/2025	8:15:00 PM	0
10/21/2025	8:30:00 PM	0
10/21/2025	8:45:00 PM	0
10/21/2025	9:00:00 PM	0
10/21/2025	9:15:00 PM	0
10/21/2025	9:30:00 PM	0
10/21/2025	9:45:00 PM	0
10/21/2025	10:00:00 PM	0
10/21/2025	10:15:00 PM	0
10/21/2025	10:30:00 PM	0
10/21/2025	10:45:00 PM	0
10/21/2025	11:00:00 PM	0
10/21/2025	11:15:00 PM	0
10/21/2025	11:30:00 PM	0
10/21/2025	11:45:00 PM	0
10/22/2025	12:00:00 AM	0
10/22/2025	12:15:00 AM	0
10/22/2025	12:30:00 AM	0
10/22/2025	12:45:00 AM	0
10/22/2025	1:00:00 AM	0
10/22/2025	1:15:00 AM	0
10/22/2025	1:30:00 AM	0
10/22/2025	1:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/22/2025	2:00:00 AM	0
10/22/2025	2:15:00 AM	0
10/22/2025	2:30:00 AM	0
10/22/2025	2:45:00 AM	0
10/22/2025	3:00:00 AM	0
10/22/2025	3:15:00 AM	0
10/22/2025	3:30:00 AM	0
10/22/2025	3:45:00 AM	0
10/22/2025	4:00:00 AM	0
10/22/2025	4:15:00 AM	0
10/22/2025	4:30:00 AM	0
10/22/2025	4:45:00 AM	0
10/22/2025	5:00:00 AM	0
10/22/2025	5:15:00 AM	0
10/22/2025	5:30:00 AM	0
10/22/2025	5:45:00 AM	0
10/22/2025	6:00:00 AM	0
10/22/2025	6:15:00 AM	0
10/22/2025	6:30:00 AM	0
10/22/2025	6:45:00 AM	0
10/22/2025	7:00:00 AM	0
10/22/2025	7:15:00 AM	0
10/22/2025	7:30:00 AM	0
10/22/2025	7:45:00 AM	0
10/22/2025	8:00:00 AM	0
10/22/2025	8:15:00 AM	0
10/22/2025	8:30:00 AM	0
10/22/2025	8:45:00 AM	0
10/22/2025	9:00:00 AM	0
10/22/2025	9:15:00 AM	0
10/22/2025	9:30:00 AM	0
10/22/2025	9:45:00 AM	0
10/22/2025	10:00:00 AM	0
10/22/2025	10:15:00 AM	0
10/22/2025	10:30:00 AM	0
10/22/2025	10:45:00 AM	0
10/22/2025	11:00:00 AM	0
10/22/2025	11:15:00 AM	0
10/22/2025	11:30:00 AM	0
10/22/2025	11:45:00 AM	0
10/22/2025	12:00:00 PM	0
10/22/2025	12:15:00 PM	0
10/22/2025	12:30:00 PM	0
10/22/2025	12:45:00 PM	0
10/22/2025	1:00:00 PM	0
10/22/2025	1:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/22/2025	1:30:00 PM	0
10/22/2025	1:45:00 PM	0
10/22/2025	2:00:00 PM	0
10/22/2025	2:15:00 PM	0
10/22/2025	2:30:00 PM	0
10/22/2025	2:45:00 PM	0
10/22/2025	3:00:00 PM	0
10/22/2025	3:15:00 PM	0
10/22/2025	3:30:00 PM	0
10/22/2025	3:45:00 PM	0
10/22/2025	4:00:00 PM	0
10/22/2025	4:15:00 PM	0
10/22/2025	4:30:00 PM	0
10/22/2025	4:45:00 PM	0
10/22/2025	5:00:00 PM	0
10/22/2025	5:15:00 PM	0
10/22/2025	5:30:00 PM	0
10/22/2025	5:45:00 PM	0
10/22/2025	6:00:00 PM	0
10/22/2025	6:15:00 PM	0
10/22/2025	6:30:00 PM	0
10/22/2025	6:45:00 PM	0
10/22/2025	7:00:00 PM	0
10/22/2025	7:15:00 PM	0
10/22/2025	7:30:00 PM	0
10/22/2025	7:45:00 PM	0
10/22/2025	8:00:00 PM	0
10/22/2025	8:15:00 PM	0
10/22/2025	8:30:00 PM	0
10/22/2025	8:45:00 PM	0
10/22/2025	9:00:00 PM	0
10/22/2025	9:15:00 PM	0
10/22/2025	9:30:00 PM	0
10/22/2025	9:45:00 PM	0
10/22/2025	10:00:00 PM	0
10/22/2025	10:15:00 PM	0
10/22/2025	10:30:00 PM	0
10/22/2025	10:45:00 PM	0
10/22/2025	11:00:00 PM	0
10/22/2025	11:15:00 PM	0
10/22/2025	11:30:00 PM	0
10/22/2025	11:45:00 PM	0
10/23/2025	12:00:00 AM	0
10/23/2025	12:15:00 AM	0
10/23/2025	12:30:00 AM	0
10/23/2025	12:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/23/2025	1:00:00 AM	0
10/23/2025	1:15:00 AM	0
10/23/2025	1:30:00 AM	0
10/23/2025	1:45:00 AM	0
10/23/2025	2:00:00 AM	0
10/23/2025	2:15:00 AM	0
10/23/2025	2:30:00 AM	0
10/23/2025	2:45:00 AM	0
10/23/2025	3:00:00 AM	0
10/23/2025	3:15:00 AM	0
10/23/2025	3:30:00 AM	0
10/23/2025	3:45:00 AM	0
10/23/2025	4:00:00 AM	0
10/23/2025	4:15:00 AM	0
10/23/2025	4:30:00 AM	0
10/23/2025	4:45:00 AM	0
10/23/2025	5:00:00 AM	0
10/23/2025	5:15:00 AM	0
10/23/2025	5:30:00 AM	0
10/23/2025	5:45:00 AM	0
10/23/2025	6:00:00 AM	0
10/23/2025	6:15:00 AM	0
10/23/2025	6:30:00 AM	0
10/23/2025	6:45:00 AM	0
10/23/2025	7:00:00 AM	0
10/23/2025	7:15:00 AM	0
10/23/2025	7:30:00 AM	0
10/23/2025	7:45:00 AM	0
10/23/2025	8:00:00 AM	0
10/23/2025	8:15:00 AM	0
10/23/2025	8:30:00 AM	0
10/23/2025	8:45:00 AM	0
10/23/2025	9:00:00 AM	0
10/23/2025	9:15:00 AM	0
10/23/2025	9:30:00 AM	0
10/23/2025	9:45:00 AM	0
10/23/2025	10:00:00 AM	0
10/23/2025	10:15:00 AM	0
10/23/2025	10:30:00 AM	0
10/23/2025	10:45:00 AM	0
10/23/2025	11:00:00 AM	0
10/23/2025	11:15:00 AM	0
10/23/2025	11:30:00 AM	0
10/23/2025	11:45:00 AM	0
10/23/2025	12:00:00 PM	0
10/23/2025	12:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/23/2025	12:30:00 PM	0
10/23/2025	12:45:00 PM	0
10/23/2025	1:00:00 PM	0
10/23/2025	1:15:00 PM	0
10/23/2025	1:30:00 PM	0
10/23/2025	1:45:00 PM	0
10/23/2025	2:00:00 PM	0
10/23/2025	2:15:00 PM	0
10/23/2025	2:30:00 PM	0
10/23/2025	2:45:00 PM	0
10/23/2025	3:00:00 PM	0
10/23/2025	3:15:00 PM	0
10/23/2025	3:30:00 PM	0
10/23/2025	3:45:00 PM	0
10/23/2025	4:00:00 PM	0
10/23/2025	4:15:00 PM	0
10/23/2025	4:30:00 PM	0
10/23/2025	4:45:00 PM	0
10/23/2025	5:00:00 PM	0
10/23/2025	5:15:00 PM	0
10/23/2025	5:30:00 PM	0
10/23/2025	5:45:00 PM	0
10/23/2025	6:00:00 PM	0
10/23/2025	6:15:00 PM	0
10/23/2025	6:30:00 PM	0
10/23/2025	6:45:00 PM	0
10/23/2025	7:00:00 PM	0
10/23/2025	7:15:00 PM	0
10/23/2025	7:30:00 PM	0
10/23/2025	7:45:00 PM	0
10/23/2025	8:00:00 PM	0
10/23/2025	8:15:00 PM	0
10/23/2025	8:30:00 PM	0
10/23/2025	8:45:00 PM	0
10/23/2025	9:00:00 PM	0
10/23/2025	9:15:00 PM	0
10/23/2025	9:30:00 PM	0
10/23/2025	9:45:00 PM	0
10/23/2025	10:00:00 PM	0
10/23/2025	10:15:00 PM	0
10/23/2025	10:30:00 PM	0
10/23/2025	10:45:00 PM	0
10/23/2025	11:00:00 PM	0
10/23/2025	11:15:00 PM	0
10/23/2025	11:30:00 PM	0
10/23/2025	11:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/24/2025	12:00:00 AM	0
10/24/2025	12:15:00 AM	0
10/24/2025	12:30:00 AM	0
10/24/2025	12:45:00 AM	0
10/24/2025	1:00:00 AM	0
10/24/2025	1:15:00 AM	0
10/24/2025	1:30:00 AM	0
10/24/2025	1:45:00 AM	0
10/24/2025	2:00:00 AM	0
10/24/2025	2:15:00 AM	0
10/24/2025	2:30:00 AM	0
10/24/2025	2:45:00 AM	0
10/24/2025	3:00:00 AM	0
10/24/2025	3:15:00 AM	0
10/24/2025	3:30:00 AM	0
10/24/2025	3:45:00 AM	0
10/24/2025	4:00:00 AM	0
10/24/2025	4:15:00 AM	0
10/24/2025	4:30:00 AM	0
10/24/2025	4:45:00 AM	0
10/24/2025	5:00:00 AM	0
10/24/2025	5:15:00 AM	0
10/24/2025	5:30:00 AM	0
10/24/2025	5:45:00 AM	0
10/24/2025	6:00:00 AM	0
10/24/2025	6:15:00 AM	0
10/24/2025	6:30:00 AM	0
10/24/2025	6:45:00 AM	0
10/24/2025	7:00:00 AM	0
10/24/2025	7:15:00 AM	0
10/24/2025	7:30:00 AM	0
10/24/2025	7:45:00 AM	0
10/24/2025	8:00:00 AM	0
10/24/2025	8:15:00 AM	0
10/24/2025	8:30:00 AM	0
10/24/2025	8:45:00 AM	0
10/24/2025	9:00:00 AM	0
10/24/2025	9:15:00 AM	0
10/24/2025	9:30:00 AM	0
10/24/2025	9:45:00 AM	0
10/24/2025	10:00:00 AM	0
10/24/2025	10:15:00 AM	0
10/24/2025	10:30:00 AM	0
10/24/2025	10:45:00 AM	0
10/24/2025	11:00:00 AM	0
10/24/2025	11:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/24/2025	11:30:00 AM	0
10/24/2025	11:45:00 AM	0
10/24/2025	12:00:00 PM	0
10/24/2025	12:15:00 PM	0
10/24/2025	12:30:00 PM	0
10/24/2025	12:45:00 PM	0
10/24/2025	1:00:00 PM	0
10/24/2025	1:15:00 PM	0
10/24/2025	1:30:00 PM	0
10/24/2025	1:45:00 PM	0
10/24/2025	2:00:00 PM	0
10/24/2025	2:15:00 PM	0
10/24/2025	2:30:00 PM	0
10/24/2025	2:45:00 PM	0
10/24/2025	3:00:00 PM	0
10/24/2025	3:15:00 PM	0
10/24/2025	3:30:00 PM	0
10/24/2025	3:45:00 PM	0
10/24/2025	4:00:00 PM	0
10/24/2025	4:15:00 PM	0
10/24/2025	4:30:00 PM	0
10/24/2025	4:45:00 PM	0
10/24/2025	5:00:00 PM	0
10/24/2025	5:15:00 PM	0
10/24/2025	5:30:00 PM	0
10/24/2025	5:45:00 PM	0
10/24/2025	6:00:00 PM	0
10/24/2025	6:15:00 PM	0
10/24/2025	6:30:00 PM	0
10/24/2025	6:45:00 PM	0
10/24/2025	7:00:00 PM	0
10/24/2025	7:15:00 PM	0
10/24/2025	7:30:00 PM	0
10/24/2025	7:45:00 PM	0
10/24/2025	8:00:00 PM	0
10/24/2025	8:15:00 PM	0
10/24/2025	8:30:00 PM	0
10/24/2025	8:45:00 PM	0
10/24/2025	9:00:00 PM	0
10/24/2025	9:15:00 PM	0
10/24/2025	9:30:00 PM	0
10/24/2025	9:45:00 PM	0
10/24/2025	10:00:00 PM	0
10/24/2025	10:15:00 PM	0
10/24/2025	10:30:00 PM	0
10/24/2025	10:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/24/2025	11:00:00 PM	0
10/24/2025	11:15:00 PM	0
10/24/2025	11:30:00 PM	0
10/24/2025	11:45:00 PM	0
10/25/2025	12:00:00 AM	0
10/25/2025	12:15:00 AM	0
10/25/2025	12:30:00 AM	0
10/25/2025	12:45:00 AM	0
10/25/2025	1:00:00 AM	0
10/25/2025	1:15:00 AM	0
10/25/2025	1:30:00 AM	0
10/25/2025	1:45:00 AM	0
10/25/2025	2:00:00 AM	0
10/25/2025	2:15:00 AM	0
10/25/2025	2:30:00 AM	0
10/25/2025	2:45:00 AM	0
10/25/2025	3:00:00 AM	0
10/25/2025	3:15:00 AM	0
10/25/2025	3:30:00 AM	0
10/25/2025	3:45:00 AM	0
10/25/2025	4:00:00 AM	0
10/25/2025	4:15:00 AM	0
10/25/2025	4:30:00 AM	0
10/25/2025	4:45:00 AM	0
10/25/2025	5:00:00 AM	0
10/25/2025	5:15:00 AM	0
10/25/2025	5:30:00 AM	0
10/25/2025	5:45:00 AM	0
10/25/2025	6:00:00 AM	0
10/25/2025	6:15:00 AM	0
10/25/2025	6:30:00 AM	0
10/25/2025	6:45:00 AM	0
10/25/2025	7:00:00 AM	0
10/25/2025	7:15:00 AM	0
10/25/2025	7:30:00 AM	0
10/25/2025	7:45:00 AM	0
10/25/2025	8:00:00 AM	0
10/25/2025	8:15:00 AM	0
10/25/2025	8:30:00 AM	0
10/25/2025	8:45:00 AM	0
10/25/2025	9:00:00 AM	0
10/25/2025	9:15:00 AM	0
10/25/2025	9:30:00 AM	0
10/25/2025	9:45:00 AM	0
10/25/2025	10:00:00 AM	0
10/25/2025	10:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/25/2025	10:30:00 AM	0
10/25/2025	10:45:00 AM	0
10/25/2025	11:00:00 AM	0
10/25/2025	11:15:00 AM	0
10/25/2025	11:30:00 AM	0
10/25/2025	11:45:00 AM	0
10/25/2025	12:00:00 PM	0
10/25/2025	12:15:00 PM	0
10/25/2025	12:30:00 PM	0
10/25/2025	12:45:00 PM	0
10/25/2025	1:00:00 PM	0
10/25/2025	1:15:00 PM	0
10/25/2025	1:30:00 PM	0
10/25/2025	1:45:00 PM	0
10/25/2025	2:00:00 PM	0
10/25/2025	2:15:00 PM	0
10/25/2025	2:30:00 PM	0
10/25/2025	2:45:00 PM	0
10/25/2025	3:00:00 PM	0
10/25/2025	3:15:00 PM	0
10/25/2025	3:30:00 PM	0
10/25/2025	3:45:00 PM	0
10/25/2025	4:00:00 PM	0
10/25/2025	4:15:00 PM	0
10/25/2025	4:30:00 PM	0
10/25/2025	4:45:00 PM	0
10/25/2025	5:00:00 PM	0
10/25/2025	5:15:00 PM	0
10/25/2025	5:30:00 PM	0
10/25/2025	5:45:00 PM	0
10/25/2025	6:00:00 PM	0
10/25/2025	6:15:00 PM	0
10/25/2025	6:30:00 PM	0
10/25/2025	6:45:00 PM	0
10/25/2025	7:00:00 PM	0
10/25/2025	7:15:00 PM	0
10/25/2025	7:30:00 PM	0
10/25/2025	7:45:00 PM	0
10/25/2025	8:00:00 PM	0
10/25/2025	8:15:00 PM	0
10/25/2025	8:30:00 PM	0
10/25/2025	8:45:00 PM	0
10/25/2025	9:00:00 PM	0
10/25/2025	9:15:00 PM	0
10/25/2025	9:30:00 PM	0
10/25/2025	9:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/25/2025	10:00:00 PM	0
10/25/2025	10:15:00 PM	0
10/25/2025	10:30:00 PM	0
10/25/2025	10:45:00 PM	0
10/25/2025	11:00:00 PM	0
10/25/2025	11:15:00 PM	0
10/25/2025	11:30:00 PM	0
10/25/2025	11:45:00 PM	0
10/26/2025	12:00:00 AM	0
10/26/2025	12:15:00 AM	0
10/26/2025	12:30:00 AM	0
10/26/2025	12:45:00 AM	0
10/26/2025	1:00:00 AM	0
10/26/2025	1:15:00 AM	0
10/26/2025	1:30:00 AM	0
10/26/2025	1:45:00 AM	0
10/26/2025	2:00:00 AM	0
10/26/2025	2:15:00 AM	0
10/26/2025	2:30:00 AM	0
10/26/2025	2:45:00 AM	0
10/26/2025	3:00:00 AM	0
10/26/2025	3:15:00 AM	0
10/26/2025	3:30:00 AM	0
10/26/2025	3:45:00 AM	0
10/26/2025	4:00:00 AM	0
10/26/2025	4:15:00 AM	0
10/26/2025	4:30:00 AM	0
10/26/2025	4:45:00 AM	0
10/26/2025	5:00:00 AM	0
10/26/2025	5:15:00 AM	0
10/26/2025	5:30:00 AM	0
10/26/2025	5:45:00 AM	0
10/26/2025	6:00:00 AM	0
10/26/2025	6:15:00 AM	0
10/26/2025	6:30:00 AM	0
10/26/2025	6:45:00 AM	0
10/26/2025	7:00:00 AM	0
10/26/2025	7:15:00 AM	0
10/26/2025	7:30:00 AM	0
10/26/2025	7:45:00 AM	0
10/26/2025	8:00:00 AM	0
10/26/2025	8:15:00 AM	0
10/26/2025	8:30:00 AM	0
10/26/2025	8:45:00 AM	0
10/26/2025	9:00:00 AM	0
10/26/2025	9:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/26/2025	9:30:00 AM	0
10/26/2025	9:45:00 AM	0
10/26/2025	10:00:00 AM	0
10/26/2025	10:15:00 AM	0
10/26/2025	10:30:00 AM	0
10/26/2025	10:45:00 AM	0
10/26/2025	11:00:00 AM	0
10/26/2025	11:15:00 AM	0
10/26/2025	11:30:00 AM	0
10/26/2025	11:45:00 AM	0
10/26/2025	12:00:00 PM	0
10/26/2025	12:15:00 PM	0
10/26/2025	12:30:00 PM	0
10/26/2025	12:45:00 PM	0
10/26/2025	1:00:00 PM	0
10/26/2025	1:15:00 PM	0
10/26/2025	1:30:00 PM	0
10/26/2025	1:45:00 PM	0
10/26/2025	2:00:00 PM	0
10/26/2025	2:15:00 PM	0
10/26/2025	2:30:00 PM	0
10/26/2025	2:45:00 PM	0
10/26/2025	3:00:00 PM	0
10/26/2025	3:15:00 PM	0
10/26/2025	3:30:00 PM	0
10/26/2025	3:45:00 PM	0
10/26/2025	4:00:00 PM	0
10/26/2025	4:15:00 PM	0
10/26/2025	4:30:00 PM	0
10/26/2025	4:45:00 PM	0
10/26/2025	5:00:00 PM	0
10/26/2025	5:15:00 PM	0
10/26/2025	5:30:00 PM	0
10/26/2025	5:45:00 PM	0
10/26/2025	6:00:00 PM	0
10/26/2025	6:15:00 PM	0
10/26/2025	6:30:00 PM	0
10/26/2025	6:45:00 PM	0
10/26/2025	7:00:00 PM	0
10/26/2025	7:15:00 PM	0
10/26/2025	7:30:00 PM	0
10/26/2025	7:45:00 PM	0
10/26/2025	8:00:00 PM	0
10/26/2025	8:15:00 PM	0
10/26/2025	8:30:00 PM	0
10/26/2025	8:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/26/2025	9:00:00 PM	0
10/26/2025	9:15:00 PM	0
10/26/2025	9:30:00 PM	0
10/26/2025	9:45:00 PM	0
10/26/2025	10:00:00 PM	0
10/26/2025	10:15:00 PM	0
10/26/2025	10:30:00 PM	0
10/26/2025	10:45:00 PM	0
10/26/2025	11:00:00 PM	0
10/26/2025	11:15:00 PM	0
10/26/2025	11:30:00 PM	0
10/26/2025	11:45:00 PM	0
10/27/2025	12:00:00 AM	0
10/27/2025	12:15:00 AM	0
10/27/2025	12:30:00 AM	0
10/27/2025	12:45:00 AM	0
10/27/2025	1:00:00 AM	0
10/27/2025	1:15:00 AM	0
10/27/2025	1:30:00 AM	0
10/27/2025	1:45:00 AM	0
10/27/2025	2:00:00 AM	0
10/27/2025	2:15:00 AM	0
10/27/2025	2:30:00 AM	0
10/27/2025	2:45:00 AM	0
10/27/2025	3:00:00 AM	0
10/27/2025	3:15:00 AM	0
10/27/2025	3:30:00 AM	0
10/27/2025	3:45:00 AM	0
10/27/2025	4:00:00 AM	0
10/27/2025	4:15:00 AM	0
10/27/2025	4:30:00 AM	0
10/27/2025	4:45:00 AM	0
10/27/2025	5:00:00 AM	0
10/27/2025	5:15:00 AM	0
10/27/2025	5:30:00 AM	0
10/27/2025	5:45:00 AM	0
10/27/2025	6:00:00 AM	0
10/27/2025	6:15:00 AM	0
10/27/2025	6:30:00 AM	0
10/27/2025	6:45:00 AM	0
10/27/2025	7:00:00 AM	0
10/27/2025	7:15:00 AM	0
10/27/2025	7:30:00 AM	0
10/27/2025	7:45:00 AM	0
10/27/2025	8:00:00 AM	0
10/27/2025	8:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/27/2025	8:30:00 AM	0
10/27/2025	8:45:00 AM	0
10/27/2025	9:00:00 AM	0
10/27/2025	9:15:00 AM	0
10/27/2025	9:30:00 AM	0
10/27/2025	9:45:00 AM	0
10/27/2025	10:00:00 AM	0
10/27/2025	10:15:00 AM	0
10/27/2025	10:30:00 AM	0
10/27/2025	10:45:00 AM	0
10/27/2025	11:00:00 AM	0
10/27/2025	11:15:00 AM	0
10/27/2025	11:30:00 AM	0
10/27/2025	11:45:00 AM	0
10/27/2025	12:00:00 PM	0
10/27/2025	12:15:00 PM	0
10/27/2025	12:30:00 PM	0
10/27/2025	12:45:00 PM	0
10/27/2025	1:00:00 PM	0
10/27/2025	1:15:00 PM	0
10/27/2025	1:30:00 PM	0
10/27/2025	1:45:00 PM	0
10/27/2025	2:00:00 PM	0
10/27/2025	2:15:00 PM	0
10/27/2025	2:30:00 PM	0
10/27/2025	2:45:00 PM	0
10/27/2025	3:00:00 PM	0
10/27/2025	3:15:00 PM	0
10/27/2025	3:30:00 PM	0
10/27/2025	3:45:00 PM	0
10/27/2025	4:00:00 PM	0
10/27/2025	4:15:00 PM	0
10/27/2025	4:30:00 PM	0
10/27/2025	4:45:00 PM	0
10/27/2025	5:00:00 PM	0
10/27/2025	5:15:00 PM	0
10/27/2025	5:30:00 PM	0
10/27/2025	5:45:00 PM	0
10/27/2025	6:00:00 PM	0
10/27/2025	6:15:00 PM	0
10/27/2025	6:30:00 PM	0
10/27/2025	6:45:00 PM	0
10/27/2025	7:00:00 PM	0
10/27/2025	7:15:00 PM	0
10/27/2025	7:30:00 PM	0
10/27/2025	7:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/27/2025	8:00:00 PM	0
10/27/2025	8:15:00 PM	0
10/27/2025	8:30:00 PM	0
10/27/2025	8:45:00 PM	0
10/27/2025	9:00:00 PM	0
10/27/2025	9:15:00 PM	0
10/27/2025	9:30:00 PM	0
10/27/2025	9:45:00 PM	0
10/27/2025	10:00:00 PM	0
10/27/2025	10:15:00 PM	0
10/27/2025	10:30:00 PM	0
10/27/2025	10:45:00 PM	0
10/27/2025	11:00:00 PM	0
10/27/2025	11:15:00 PM	0
10/27/2025	11:30:00 PM	0
10/27/2025	11:45:00 PM	0
10/28/2025	12:00:00 AM	0
10/28/2025	12:15:00 AM	0
10/28/2025	12:30:00 AM	0
10/28/2025	12:45:00 AM	0
10/28/2025	1:00:00 AM	0
10/28/2025	1:15:00 AM	0
10/28/2025	1:30:00 AM	0
10/28/2025	1:45:00 AM	0
10/28/2025	2:00:00 AM	0
10/28/2025	2:15:00 AM	0
10/28/2025	2:30:00 AM	0
10/28/2025	2:45:00 AM	0
10/28/2025	3:00:00 AM	0
10/28/2025	3:15:00 AM	0
10/28/2025	3:30:00 AM	0
10/28/2025	3:45:00 AM	0
10/28/2025	4:00:00 AM	0
10/28/2025	4:15:00 AM	0
10/28/2025	4:30:00 AM	0
10/28/2025	4:45:00 AM	0
10/28/2025	5:00:00 AM	0
10/28/2025	5:15:00 AM	0
10/28/2025	5:30:00 AM	0
10/28/2025	5:45:00 AM	0
10/28/2025	6:00:00 AM	0
10/28/2025	6:15:00 AM	0
10/28/2025	6:30:00 AM	0
10/28/2025	6:45:00 AM	0
10/28/2025	7:00:00 AM	0
10/28/2025	7:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/28/2025	7:30:00 AM	0
10/28/2025	7:45:00 AM	0
10/28/2025	8:00:00 AM	0
10/28/2025	8:15:00 AM	0
10/28/2025	8:30:00 AM	0
10/28/2025	8:45:00 AM	0
10/28/2025	9:00:00 AM	0
10/28/2025	9:15:00 AM	0
10/28/2025	9:30:00 AM	0
10/28/2025	9:45:00 AM	0
10/28/2025	10:00:00 AM	0
10/28/2025	10:15:00 AM	0
10/28/2025	10:30:00 AM	0
10/28/2025	10:45:00 AM	0
10/28/2025	11:00:00 AM	0
10/28/2025	11:15:00 AM	0
10/28/2025	11:30:00 AM	0
10/28/2025	11:45:00 AM	0
10/28/2025	12:00:00 PM	0
10/28/2025	12:15:00 PM	0
10/28/2025	12:30:00 PM	0
10/28/2025	12:45:00 PM	0
10/28/2025	1:00:00 PM	0
10/28/2025	1:15:00 PM	0
10/28/2025	1:30:00 PM	0
10/28/2025	1:45:00 PM	0
10/28/2025	2:00:00 PM	0
10/28/2025	2:15:00 PM	0
10/28/2025	2:30:00 PM	0
10/28/2025	2:45:00 PM	0
10/28/2025	3:00:00 PM	0
10/28/2025	3:15:00 PM	0
10/28/2025	3:30:00 PM	0
10/28/2025	3:45:00 PM	0
10/28/2025	4:00:00 PM	0
10/28/2025	4:15:00 PM	0
10/28/2025	4:30:00 PM	0
10/28/2025	4:45:00 PM	0
10/28/2025	5:00:00 PM	0
10/28/2025	5:15:00 PM	0
10/28/2025	5:30:00 PM	0
10/28/2025	5:45:00 PM	0
10/28/2025	6:00:00 PM	0
10/28/2025	6:15:00 PM	0
10/28/2025	6:30:00 PM	0
10/28/2025	6:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/28/2025	7:00:00 PM	0
10/28/2025	7:15:00 PM	0
10/28/2025	7:30:00 PM	0
10/28/2025	7:45:00 PM	0
10/28/2025	8:00:00 PM	0
10/28/2025	8:15:00 PM	0
10/28/2025	8:30:00 PM	0
10/28/2025	8:45:00 PM	0
10/28/2025	9:00:00 PM	0
10/28/2025	9:15:00 PM	0
10/28/2025	9:30:00 PM	0
10/28/2025	9:45:00 PM	0
10/28/2025	10:00:00 PM	0
10/28/2025	10:15:00 PM	0
10/28/2025	10:30:00 PM	0
10/28/2025	10:45:00 PM	0
10/28/2025	11:00:00 PM	0
10/28/2025	11:15:00 PM	0
10/28/2025	11:30:00 PM	0
10/28/2025	11:45:00 PM	0
10/29/2025	12:00:00 AM	0
10/29/2025	12:15:00 AM	0
10/29/2025	12:30:00 AM	0
10/29/2025	12:45:00 AM	0
10/29/2025	1:00:00 AM	0
10/29/2025	1:15:00 AM	0
10/29/2025	1:30:00 AM	0
10/29/2025	1:45:00 AM	0
10/29/2025	2:00:00 AM	0
10/29/2025	2:15:00 AM	0
10/29/2025	2:30:00 AM	0
10/29/2025	2:45:00 AM	0
10/29/2025	3:00:00 AM	0
10/29/2025	3:15:00 AM	0
10/29/2025	3:30:00 AM	0
10/29/2025	3:45:00 AM	0
10/29/2025	4:00:00 AM	0
10/29/2025	4:15:00 AM	0
10/29/2025	4:30:00 AM	0
10/29/2025	4:45:00 AM	0
10/29/2025	5:00:00 AM	0
10/29/2025	5:15:00 AM	0
10/29/2025	5:30:00 AM	0
10/29/2025	5:45:00 AM	0
10/29/2025	6:00:00 AM	0
10/29/2025	6:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/29/2025	6:30:00 AM	0
10/29/2025	6:45:00 AM	0
10/29/2025	7:00:00 AM	0
10/29/2025	7:15:00 AM	0
10/29/2025	7:30:00 AM	0
10/29/2025	7:45:00 AM	0
10/29/2025	8:00:00 AM	0
10/29/2025	8:15:00 AM	0
10/29/2025	8:30:00 AM	0
10/29/2025	8:45:00 AM	0
10/29/2025	9:00:00 AM	0
10/29/2025	9:15:00 AM	0
10/29/2025	9:30:00 AM	0
10/29/2025	9:45:00 AM	0
10/29/2025	10:00:00 AM	0
10/29/2025	10:15:00 AM	0
10/29/2025	10:30:00 AM	0
10/29/2025	10:45:00 AM	0
10/29/2025	11:00:00 AM	0
10/29/2025	11:15:00 AM	0
10/29/2025	11:30:00 AM	0
10/29/2025	11:45:00 AM	0
10/29/2025	12:00:00 PM	0
10/29/2025	12:15:00 PM	0
10/29/2025	12:30:00 PM	0
10/29/2025	12:45:00 PM	0
10/29/2025	1:00:00 PM	0
10/29/2025	1:15:00 PM	0
10/29/2025	1:30:00 PM	0
10/29/2025	1:45:00 PM	0
10/29/2025	2:00:00 PM	0
10/29/2025	2:15:00 PM	0
10/29/2025	2:30:00 PM	0
10/29/2025	2:45:00 PM	0
10/29/2025	3:00:00 PM	0
10/29/2025	3:15:00 PM	0
10/29/2025	3:30:00 PM	0
10/29/2025	3:45:00 PM	0
10/29/2025	4:00:00 PM	0
10/29/2025	4:15:00 PM	0
10/29/2025	4:30:00 PM	0
10/29/2025	4:45:00 PM	0
10/29/2025	5:00:00 PM	0
10/29/2025	5:15:00 PM	0
10/29/2025	5:30:00 PM	0
10/29/2025	5:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/29/2025	6:00:00 PM	0
10/29/2025	6:15:00 PM	0
10/29/2025	6:30:00 PM	0
10/29/2025	6:45:00 PM	0
10/29/2025	7:00:00 PM	0
10/29/2025	7:15:00 PM	0
10/29/2025	7:30:00 PM	0
10/29/2025	7:45:00 PM	0
10/29/2025	8:00:00 PM	0
10/29/2025	8:15:00 PM	0
10/29/2025	8:30:00 PM	0
10/29/2025	8:45:00 PM	0
10/29/2025	9:00:00 PM	0
10/29/2025	9:15:00 PM	0
10/29/2025	9:30:00 PM	0
10/29/2025	9:45:00 PM	0
10/29/2025	10:00:00 PM	0
10/29/2025	10:15:00 PM	0
10/29/2025	10:30:00 PM	0
10/29/2025	10:45:00 PM	0
10/29/2025	11:00:00 PM	0
10/29/2025	11:15:00 PM	0
10/29/2025	11:30:00 PM	0
10/29/2025	11:45:00 PM	0
10/30/2025	12:00:00 AM	0
10/30/2025	12:15:00 AM	0
10/30/2025	12:30:00 AM	0
10/30/2025	12:45:00 AM	0
10/30/2025	1:00:00 AM	0
10/30/2025	1:15:00 AM	0
10/30/2025	1:30:00 AM	0
10/30/2025	1:45:00 AM	0
10/30/2025	2:00:00 AM	0
10/30/2025	2:15:00 AM	0
10/30/2025	2:30:00 AM	0
10/30/2025	2:45:00 AM	0
10/30/2025	3:00:00 AM	0
10/30/2025	3:15:00 AM	0
10/30/2025	3:30:00 AM	0
10/30/2025	3:45:00 AM	0
10/30/2025	4:00:00 AM	0
10/30/2025	4:15:00 AM	0
10/30/2025	4:30:00 AM	0
10/30/2025	4:45:00 AM	0
10/30/2025	5:00:00 AM	0
10/30/2025	5:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/30/2025	5:30:00 AM	0
10/30/2025	5:45:00 AM	0
10/30/2025	6:00:00 AM	0
10/30/2025	6:15:00 AM	0
10/30/2025	6:30:00 AM	0
10/30/2025	6:45:00 AM	0
10/30/2025	7:00:00 AM	0
10/30/2025	7:15:00 AM	0
10/30/2025	7:30:00 AM	0
10/30/2025	7:45:00 AM	0
10/30/2025	8:00:00 AM	0
10/30/2025	8:15:00 AM	0
10/30/2025	8:30:00 AM	0
10/30/2025	8:45:00 AM	0
10/30/2025	9:00:00 AM	0
10/30/2025	9:15:00 AM	0
10/30/2025	9:30:00 AM	0
10/30/2025	9:45:00 AM	0
10/30/2025	10:00:00 AM	0
10/30/2025	10:15:00 AM	0
10/30/2025	10:30:00 AM	0
10/30/2025	10:45:00 AM	0
10/30/2025	11:00:00 AM	0
10/30/2025	11:15:00 AM	0
10/30/2025	11:30:00 AM	0
10/30/2025	11:45:00 AM	0
10/30/2025	12:00:00 PM	0
10/30/2025	12:15:00 PM	0
10/30/2025	12:30:00 PM	0
10/30/2025	12:45:00 PM	0
10/30/2025	1:00:00 PM	0
10/30/2025	1:15:00 PM	0
10/30/2025	1:30:00 PM	0
10/30/2025	1:45:00 PM	0
10/30/2025	2:00:00 PM	0
10/30/2025	2:15:00 PM	0
10/30/2025	2:30:00 PM	0
10/30/2025	2:45:00 PM	0
10/30/2025	3:00:00 PM	0
10/30/2025	3:15:00 PM	0
10/30/2025	3:30:00 PM	0
10/30/2025	3:45:00 PM	0
10/30/2025	4:00:00 PM	0
10/30/2025	4:15:00 PM	0
10/30/2025	4:30:00 PM	0
10/30/2025	4:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/30/2025	5:00:00 PM	0
10/30/2025	5:15:00 PM	0
10/30/2025	5:30:00 PM	0
10/30/2025	5:45:00 PM	0
10/30/2025	6:00:00 PM	0
10/30/2025	6:15:00 PM	0
10/30/2025	6:30:00 PM	0
10/30/2025	6:45:00 PM	0
10/30/2025	7:00:00 PM	0
10/30/2025	7:15:00 PM	0
10/30/2025	7:30:00 PM	0
10/30/2025	7:45:00 PM	0
10/30/2025	8:00:00 PM	0
10/30/2025	8:15:00 PM	0
10/30/2025	8:30:00 PM	0
10/30/2025	8:45:00 PM	0
10/30/2025	9:00:00 PM	0
10/30/2025	9:15:00 PM	0
10/30/2025	9:30:00 PM	0
10/30/2025	9:45:00 PM	0
10/30/2025	10:00:00 PM	0
10/30/2025	10:15:00 PM	0
10/30/2025	10:30:00 PM	0
10/30/2025	10:45:00 PM	0
10/30/2025	11:00:00 PM	0
10/30/2025	11:15:00 PM	0
10/30/2025	11:30:00 PM	0
10/30/2025	11:45:00 PM	0
10/31/2025	12:00:00 AM	0
10/31/2025	12:15:00 AM	0
10/31/2025	12:30:00 AM	0
10/31/2025	12:45:00 AM	0
10/31/2025	1:00:00 AM	0
10/31/2025	1:15:00 AM	0
10/31/2025	1:30:00 AM	0
10/31/2025	1:45:00 AM	0
10/31/2025	2:00:00 AM	0
10/31/2025	2:15:00 AM	0
10/31/2025	2:30:00 AM	0
10/31/2025	2:45:00 AM	0
10/31/2025	3:00:00 AM	0
10/31/2025	3:15:00 AM	0
10/31/2025	3:30:00 AM	0
10/31/2025	3:45:00 AM	0
10/31/2025	4:00:00 AM	0
10/31/2025	4:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/31/2025	4:30:00 AM	0
10/31/2025	4:45:00 AM	0
10/31/2025	5:00:00 AM	0
10/31/2025	5:15:00 AM	0
10/31/2025	5:30:00 AM	0
10/31/2025	5:45:00 AM	0
10/31/2025	6:00:00 AM	0
10/31/2025	6:15:00 AM	0
10/31/2025	6:30:00 AM	0
10/31/2025	6:45:00 AM	0
10/31/2025	7:00:00 AM	0
10/31/2025	7:15:00 AM	0
10/31/2025	7:30:00 AM	0
10/31/2025	7:45:00 AM	0
10/31/2025	8:00:00 AM	0
10/31/2025	8:15:00 AM	0
10/31/2025	8:30:00 AM	0
10/31/2025	8:45:00 AM	0
10/31/2025	9:00:00 AM	0
10/31/2025	9:15:00 AM	0
10/31/2025	9:30:00 AM	0
10/31/2025	9:45:00 AM	0
10/31/2025	10:00:00 AM	0
10/31/2025	10:15:00 AM	0
10/31/2025	10:30:00 AM	0
10/31/2025	10:45:00 AM	0
10/31/2025	11:00:00 AM	0
10/31/2025	11:15:00 AM	0
10/31/2025	11:30:00 AM	0
10/31/2025	11:45:00 AM	0
10/31/2025	12:00:00 PM	0
10/31/2025	12:15:00 PM	0
10/31/2025	12:30:00 PM	0
10/31/2025	12:45:00 PM	0
10/31/2025	1:00:00 PM	0
10/31/2025	1:15:00 PM	0
10/31/2025	1:30:00 PM	0
10/31/2025	1:45:00 PM	0
10/31/2025	2:00:00 PM	0
10/31/2025	2:15:00 PM	0
10/31/2025	2:30:00 PM	0
10/31/2025	2:45:00 PM	0
10/31/2025	3:00:00 PM	0
10/31/2025	3:15:00 PM	0
10/31/2025	3:30:00 PM	0
10/31/2025	3:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
10/31/2025	4:00:00 PM	0
10/31/2025	4:15:00 PM	0
10/31/2025	4:30:00 PM	0
10/31/2025	4:45:00 PM	0
10/31/2025	5:00:00 PM	0
10/31/2025	5:15:00 PM	0
10/31/2025	5:30:00 PM	0
10/31/2025	5:45:00 PM	0
10/31/2025	6:00:00 PM	0
10/31/2025	6:15:00 PM	0
10/31/2025	6:30:00 PM	0
10/31/2025	6:45:00 PM	0
10/31/2025	7:00:00 PM	0
10/31/2025	7:15:00 PM	0
10/31/2025	7:30:00 PM	0
10/31/2025	7:45:00 PM	0
10/31/2025	8:00:00 PM	0
10/31/2025	8:15:00 PM	0
10/31/2025	8:30:00 PM	0
10/31/2025	8:45:00 PM	0
10/31/2025	9:00:00 PM	0
10/31/2025	9:15:00 PM	0
10/31/2025	9:30:00 PM	0
10/31/2025	9:45:00 PM	0
10/31/2025	10:00:00 PM	0
10/31/2025	10:15:00 PM	0
10/31/2025	10:30:00 PM	0
10/31/2025	10:45:00 PM	0
10/31/2025	11:00:00 PM	0
10/31/2025	11:15:00 PM	0
10/31/2025	11:30:00 PM	0
10/31/2025	11:45:00 PM	0

Georges Ditch Return
Station 0217

Date	Flow (cfs)
10/1/2025	0.18
10/2/2025	0.18
10/3/2025	0.24
10/4/2025	0.19
10/5/2025	0.16
10/6/2025	0.18
10/7/2025	0.21
10/8/2025	0.29
10/9/2025	0.28
10/10/2025	0.31
10/11/2025	0.31
10/12/2025	0.26
10/13/2025	0.24
10/14/2025	0.35
10/15/2025	0.32
10/16/2025	0.29
10/17/2025	0.21
10/18/2025	0.22
10/19/2025	0.19
10/20/2025	0.20
10/21/2025	0.25
10/22/2025	0.38
10/23/2025	0.46
10/24/2025	0.49
10/25/2025	0.49
10/26/2025	0.36
10/27/2025	0.29
10/28/2025	0.38
10/29/2025	0.33
10/30/2025	0.28
10/31/2025	0.28

Georges Ditch Return Gage

DATE	TIME	GAGE
10/1/2025	12:00:00 AM	0.05
10/1/2025	12:15:00 AM	0.06
10/1/2025	12:30:00 AM	0.06
10/1/2025	12:45:00 AM	0.06
10/1/2025	1:00:00 AM	0.06
10/1/2025	1:15:00 AM	0.06
10/1/2025	1:30:00 AM	0.06
10/1/2025	1:45:00 AM	0.06
10/1/2025	2:00:00 AM	0.06
10/1/2025	2:15:00 AM	0.06
10/1/2025	2:30:00 AM	0.06
10/1/2025	2:45:00 AM	0.06
10/1/2025	3:00:00 AM	0.06
10/1/2025	3:15:00 AM	0.06
10/1/2025	3:30:00 AM	0.06
10/1/2025	3:45:00 AM	0.06
10/1/2025	4:00:00 AM	0.06
10/1/2025	4:15:00 AM	0.06
10/1/2025	4:30:00 AM	0.06
10/1/2025	4:45:00 AM	0.06
10/1/2025	5:00:00 AM	0.06
10/1/2025	5:15:00 AM	0.06
10/1/2025	5:30:00 AM	0.06
10/1/2025	5:45:00 AM	0.06
10/1/2025	6:00:00 AM	0.06
10/1/2025	6:15:00 AM	0.06
10/1/2025	6:30:00 AM	0.06
10/1/2025	6:45:00 AM	0.06
10/1/2025	7:00:00 AM	0
10/1/2025	7:15:00 AM	0.05
10/1/2025	7:30:00 AM	0.05
10/1/2025	7:45:00 AM	0.05
10/1/2025	8:00:00 AM	0.05
10/1/2025	8:15:00 AM	0.05
10/1/2025	8:30:00 AM	0.05
10/1/2025	8:45:00 AM	0.05
10/1/2025	9:00:00 AM	0.05
10/1/2025	9:15:00 AM	0.05
10/1/2025	9:30:00 AM	0.05
10/1/2025	9:45:00 AM	0.05
10/1/2025	10:00:00 AM	0.06
10/1/2025	10:15:00 AM	0.05
10/1/2025	10:30:00 AM	0.06
10/1/2025	10:45:00 AM	0.06
10/1/2025	11:00:00 AM	0.06
10/1/2025	11:15:00 AM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
10/1/2025	11:30:00 AM	0.05
10/1/2025	11:45:00 AM	0.05
10/1/2025	12:00:00 PM	0.05
10/1/2025	12:15:00 PM	0.05
10/1/2025	12:30:00 PM	0.05
10/1/2025	12:45:00 PM	0.05
10/1/2025	1:00:00 PM	0.05
10/1/2025	1:15:00 PM	0.05
10/1/2025	1:30:00 PM	0.05
10/1/2025	1:45:00 PM	0.05
10/1/2025	2:00:00 PM	0.05
10/1/2025	2:15:00 PM	0.05
10/1/2025	2:30:00 PM	0.04
10/1/2025	2:45:00 PM	0.04
10/1/2025	3:00:00 PM	0.04
10/1/2025	3:15:00 PM	0.04
10/1/2025	3:30:00 PM	0.04
10/1/2025	3:45:00 PM	0.04
10/1/2025	4:00:00 PM	0.04
10/1/2025	4:15:00 PM	0.04
10/1/2025	4:30:00 PM	0.04
10/1/2025	4:45:00 PM	0.04
10/1/2025	5:00:00 PM	0.04
10/1/2025	5:15:00 PM	0.04
10/1/2025	5:30:00 PM	0.03
10/1/2025	5:45:00 PM	0.03
10/1/2025	6:00:00 PM	0.03
10/1/2025	6:15:00 PM	0.03
10/1/2025	6:30:00 PM	0.03
10/1/2025	6:45:00 PM	0.03
10/1/2025	7:00:00 PM	0.03
10/1/2025	7:15:00 PM	0.03
10/1/2025	7:30:00 PM	0.03
10/1/2025	7:45:00 PM	0.03
10/1/2025	8:00:00 PM	0.03
10/1/2025	8:15:00 PM	0.03
10/1/2025	8:30:00 PM	0.03
10/1/2025	8:45:00 PM	0.03
10/1/2025	9:00:00 PM	0.03
10/1/2025	9:15:00 PM	0.03
10/1/2025	9:30:00 PM	0.03
10/1/2025	9:45:00 PM	0.04
10/1/2025	10:00:00 PM	0.04
10/1/2025	10:15:00 PM	0.04
10/1/2025	10:30:00 PM	0.04
10/1/2025	10:45:00 PM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
10/1/2025	11:00:00 PM	0.04
10/1/2025	11:15:00 PM	0.05
10/1/2025	11:30:00 PM	0.05
10/1/2025	11:45:00 PM	0.05
10/2/2025	12:00:00 AM	0.05
10/2/2025	12:15:00 AM	0.05
10/2/2025	12:30:00 AM	0.05
10/2/2025	12:45:00 AM	0.05
10/2/2025	1:00:00 AM	0.05
10/2/2025	1:15:00 AM	0.05
10/2/2025	1:30:00 AM	0.05
10/2/2025	1:45:00 AM	0.05
10/2/2025	2:00:00 AM	0.05
10/2/2025	2:15:00 AM	0.05
10/2/2025	2:30:00 AM	0.05
10/2/2025	2:45:00 AM	0.05
10/2/2025	3:00:00 AM	0.05
10/2/2025	3:15:00 AM	0.05
10/2/2025	3:30:00 AM	0.05
10/2/2025	3:45:00 AM	0.05
10/2/2025	4:00:00 AM	0.05
10/2/2025	4:15:00 AM	0.05
10/2/2025	4:30:00 AM	0.05
10/2/2025	4:45:00 AM	0.05
10/2/2025	5:00:00 AM	0.05
10/2/2025	5:15:00 AM	0.05
10/2/2025	5:30:00 AM	0.05
10/2/2025	5:45:00 AM	0.05
10/2/2025	6:00:00 AM	0.05
10/2/2025	6:15:00 AM	0.05
10/2/2025	6:30:00 AM	0.05
10/2/2025	6:45:00 AM	0.05
10/2/2025	7:00:00 AM	0.05
10/2/2025	7:15:00 AM	0.05
10/2/2025	7:30:00 AM	0.05
10/2/2025	7:45:00 AM	0.05
10/2/2025	8:00:00 AM	0.05
10/2/2025	8:15:00 AM	0.05
10/2/2025	8:30:00 AM	0.05
10/2/2025	8:45:00 AM	0.05
10/2/2025	9:00:00 AM	0.05
10/2/2025	9:15:00 AM	0.05
10/2/2025	9:30:00 AM	0.05
10/2/2025	9:45:00 AM	0.05
10/2/2025	10:00:00 AM	0.05
10/2/2025	10:15:00 AM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
10/2/2025	10:30:00 AM	0.05
10/2/2025	10:45:00 AM	0.05
10/2/2025	11:00:00 AM	0.05
10/2/2025	11:15:00 AM	0.05
10/2/2025	11:30:00 AM	0.05
10/2/2025	11:45:00 AM	0.05
10/2/2025	12:00:00 PM	0.05
10/2/2025	12:15:00 PM	0.05
10/2/2025	12:30:00 PM	0.04
10/2/2025	12:45:00 PM	0.05
10/2/2025	1:00:00 PM	0.05
10/2/2025	1:15:00 PM	0.04
10/2/2025	1:30:00 PM	0.04
10/2/2025	1:45:00 PM	0.04
10/2/2025	2:00:00 PM	0.04
10/2/2025	2:15:00 PM	0.04
10/2/2025	2:30:00 PM	0.04
10/2/2025	2:45:00 PM	0.04
10/2/2025	3:00:00 PM	0.04
10/2/2025	3:15:00 PM	0.04
10/2/2025	3:30:00 PM	0.04
10/2/2025	3:45:00 PM	0.04
10/2/2025	4:00:00 PM	0.03
10/2/2025	4:15:00 PM	0.03
10/2/2025	4:30:00 PM	0.03
10/2/2025	4:45:00 PM	0.03
10/2/2025	5:00:00 PM	0.03
10/2/2025	5:15:00 PM	0.04
10/2/2025	5:30:00 PM	0.04
10/2/2025	5:45:00 PM	0.04
10/2/2025	6:00:00 PM	0.04
10/2/2025	6:15:00 PM	0.04
10/2/2025	6:30:00 PM	0.04
10/2/2025	6:45:00 PM	0.04
10/2/2025	7:00:00 PM	0.05
10/2/2025	7:15:00 PM	0.05
10/2/2025	7:30:00 PM	0.05
10/2/2025	7:45:00 PM	0.05
10/2/2025	8:00:00 PM	0.05
10/2/2025	8:15:00 PM	0.05
10/2/2025	8:30:00 PM	0.05
10/2/2025	8:45:00 PM	0.05
10/2/2025	9:00:00 PM	0.05
10/2/2025	9:15:00 PM	0.05
10/2/2025	9:30:00 PM	0.05
10/2/2025	9:45:00 PM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
10/2/2025	10:00:00 PM	0.06
10/2/2025	10:15:00 PM	0.06
10/2/2025	10:30:00 PM	0.06
10/2/2025	10:45:00 PM	0.06
10/2/2025	11:00:00 PM	0.06
10/2/2025	11:15:00 PM	0.06
10/2/2025	11:30:00 PM	0.06
10/2/2025	11:45:00 PM	0.06
10/3/2025	12:00:00 AM	0.06
10/3/2025	12:15:00 AM	0.06
10/3/2025	12:30:00 AM	0.06
10/3/2025	12:45:00 AM	0.06
10/3/2025	1:00:00 AM	0.06
10/3/2025	1:15:00 AM	0.06
10/3/2025	1:30:00 AM	0.06
10/3/2025	1:45:00 AM	0.06
10/3/2025	2:00:00 AM	0.06
10/3/2025	2:15:00 AM	0.06
10/3/2025	2:30:00 AM	0.06
10/3/2025	2:45:00 AM	0.06
10/3/2025	3:00:00 AM	0.06
10/3/2025	3:15:00 AM	0.06
10/3/2025	3:30:00 AM	0.06
10/3/2025	3:45:00 AM	0.06
10/3/2025	4:00:00 AM	0.06
10/3/2025	4:15:00 AM	0.06
10/3/2025	4:30:00 AM	0.06
10/3/2025	4:45:00 AM	0.06
10/3/2025	5:00:00 AM	0.06
10/3/2025	5:15:00 AM	0.06
10/3/2025	5:30:00 AM	0.06
10/3/2025	5:45:00 AM	0.06
10/3/2025	6:00:00 AM	0.06
10/3/2025	6:15:00 AM	0.06
10/3/2025	6:30:00 AM	0.06
10/3/2025	6:45:00 AM	0.06
10/3/2025	7:00:00 AM	0.06
10/3/2025	7:15:00 AM	0.06
10/3/2025	7:30:00 AM	0.06
10/3/2025	7:45:00 AM	0.06
10/3/2025	8:00:00 AM	0.06
10/3/2025	8:15:00 AM	0.06
10/3/2025	8:30:00 AM	0.06
10/3/2025	8:45:00 AM	0.06
10/3/2025	9:00:00 AM	0.06
10/3/2025	9:15:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/3/2025	9:30:00 AM	0.06
10/3/2025	9:45:00 AM	0.06
10/3/2025	10:00:00 AM	0.06
10/3/2025	10:15:00 AM	0.06
10/3/2025	10:30:00 AM	0.06
10/3/2025	10:45:00 AM	0.06
10/3/2025	11:00:00 AM	0.06
10/3/2025	11:15:00 AM	0.06
10/3/2025	11:30:00 AM	0.06
10/3/2025	11:45:00 AM	0.06
10/3/2025	12:00:00 PM	0.06
10/3/2025	12:15:00 PM	0.06
10/3/2025	12:30:00 PM	0.06
10/3/2025	12:45:00 PM	0.06
10/3/2025	1:00:00 PM	0.06
10/3/2025	1:15:00 PM	0.05
10/3/2025	1:30:00 PM	0.06
10/3/2025	1:45:00 PM	0.06
10/3/2025	2:00:00 PM	0.06
10/3/2025	2:15:00 PM	0.05
10/3/2025	2:30:00 PM	0.05
10/3/2025	2:45:00 PM	0.05
10/3/2025	3:00:00 PM	0.05
10/3/2025	3:15:00 PM	0.05
10/3/2025	3:30:00 PM	0.05
10/3/2025	3:45:00 PM	0.05
10/3/2025	4:00:00 PM	0.05
10/3/2025	4:15:00 PM	0.05
10/3/2025	4:30:00 PM	0.06
10/3/2025	4:45:00 PM	0.06
10/3/2025	5:00:00 PM	0.06
10/3/2025	5:15:00 PM	0.06
10/3/2025	5:30:00 PM	0.06
10/3/2025	5:45:00 PM	0.06
10/3/2025	6:00:00 PM	0.06
10/3/2025	6:15:00 PM	0.06
10/3/2025	6:30:00 PM	0.06
10/3/2025	6:45:00 PM	0.06
10/3/2025	7:00:00 PM	0.06
10/3/2025	7:15:00 PM	0.06
10/3/2025	7:30:00 PM	0.06
10/3/2025	7:45:00 PM	0.06
10/3/2025	8:00:00 PM	0.06
10/3/2025	8:15:00 PM	0.06
10/3/2025	8:30:00 PM	0.06
10/3/2025	8:45:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/3/2025	9:00:00 PM	0.06
10/3/2025	9:15:00 PM	0.06
10/3/2025	9:30:00 PM	0.06
10/3/2025	9:45:00 PM	0.06
10/3/2025	10:00:00 PM	0.06
10/3/2025	10:15:00 PM	0.06
10/3/2025	10:30:00 PM	0.06
10/3/2025	10:45:00 PM	0.06
10/3/2025	11:00:00 PM	0.06
10/3/2025	11:15:00 PM	0.06
10/3/2025	11:30:00 PM	0.06
10/3/2025	11:45:00 PM	0.06
10/4/2025	12:00:00 AM	0.06
10/4/2025	12:15:00 AM	0.06
10/4/2025	12:30:00 AM	0.06
10/4/2025	12:45:00 AM	0.06
10/4/2025	1:00:00 AM	0.06
10/4/2025	1:15:00 AM	0.06
10/4/2025	1:30:00 AM	0.06
10/4/2025	1:45:00 AM	0.06
10/4/2025	2:00:00 AM	0.06
10/4/2025	2:15:00 AM	0.06
10/4/2025	2:30:00 AM	0.06
10/4/2025	2:45:00 AM	0.06
10/4/2025	3:00:00 AM	0.06
10/4/2025	3:15:00 AM	0.06
10/4/2025	3:30:00 AM	0.06
10/4/2025	3:45:00 AM	0.06
10/4/2025	4:00:00 AM	0.06
10/4/2025	4:15:00 AM	0.06
10/4/2025	4:30:00 AM	0.06
10/4/2025	4:45:00 AM	0.06
10/4/2025	5:00:00 AM	0.06
10/4/2025	5:15:00 AM	0.06
10/4/2025	5:30:00 AM	0.06
10/4/2025	5:45:00 AM	0.06
10/4/2025	6:00:00 AM	0.06
10/4/2025	6:15:00 AM	0.06
10/4/2025	6:30:00 AM	0.06
10/4/2025	6:45:00 AM	0.06
10/4/2025	7:00:00 AM	0.06
10/4/2025	7:15:00 AM	0.06
10/4/2025	7:30:00 AM	0.06
10/4/2025	7:45:00 AM	0.06
10/4/2025	8:00:00 AM	0.06
10/4/2025	8:15:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/4/2025	8:30:00 AM	0.06
10/4/2025	8:45:00 AM	0.06
10/4/2025	9:00:00 AM	0.06
10/4/2025	9:15:00 AM	0.06
10/4/2025	9:30:00 AM	0.06
10/4/2025	9:45:00 AM	0.06
10/4/2025	10:00:00 AM	0.06
10/4/2025	10:15:00 AM	0.06
10/4/2025	10:30:00 AM	0.05
10/4/2025	10:45:00 AM	0.05
10/4/2025	11:00:00 AM	0.05
10/4/2025	11:15:00 AM	0.05
10/4/2025	11:30:00 AM	0.05
10/4/2025	11:45:00 AM	0.05
10/4/2025	12:00:00 PM	0.05
10/4/2025	12:15:00 PM	0.05
10/4/2025	12:30:00 PM	0.05
10/4/2025	12:45:00 PM	0.05
10/4/2025	1:00:00 PM	0.05
10/4/2025	1:15:00 PM	0.05
10/4/2025	1:30:00 PM	0.05
10/4/2025	1:45:00 PM	0.05
10/4/2025	2:00:00 PM	0.05
10/4/2025	2:15:00 PM	0.05
10/4/2025	2:30:00 PM	0.05
10/4/2025	2:45:00 PM	0.05
10/4/2025	3:00:00 PM	0.04
10/4/2025	3:15:00 PM	0.04
10/4/2025	3:30:00 PM	0.04
10/4/2025	3:45:00 PM	0.04
10/4/2025	4:00:00 PM	0.04
10/4/2025	4:15:00 PM	0.04
10/4/2025	4:30:00 PM	0.04
10/4/2025	4:45:00 PM	0.04
10/4/2025	5:00:00 PM	0.04
10/4/2025	5:15:00 PM	0.04
10/4/2025	5:30:00 PM	0.04
10/4/2025	5:45:00 PM	0.04
10/4/2025	6:00:00 PM	0.04
10/4/2025	6:15:00 PM	0.04
10/4/2025	6:30:00 PM	0.04
10/4/2025	6:45:00 PM	0.04
10/4/2025	7:00:00 PM	0.04
10/4/2025	7:15:00 PM	0.04
10/4/2025	7:30:00 PM	0.04
10/4/2025	7:45:00 PM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
10/4/2025	8:00:00 PM	0.04
10/4/2025	8:15:00 PM	0.04
10/4/2025	8:30:00 PM	0.04
10/4/2025	8:45:00 PM	0.04
10/4/2025	9:00:00 PM	0.04
10/4/2025	9:15:00 PM	0.04
10/4/2025	9:30:00 PM	0.04
10/4/2025	9:45:00 PM	0.04
10/4/2025	10:00:00 PM	0.04
10/4/2025	10:15:00 PM	0.04
10/4/2025	10:30:00 PM	0.04
10/4/2025	10:45:00 PM	0.04
10/4/2025	11:00:00 PM	0.04
10/4/2025	11:15:00 PM	0.04
10/4/2025	11:30:00 PM	0.04
10/4/2025	11:45:00 PM	0.04
10/5/2025	12:00:00 AM	0.04
10/5/2025	12:15:00 AM	0.04
10/5/2025	12:30:00 AM	0.04
10/5/2025	12:45:00 AM	0.04
10/5/2025	1:00:00 AM	0.04
10/5/2025	1:15:00 AM	0.04
10/5/2025	1:30:00 AM	0.04
10/5/2025	1:45:00 AM	0.04
10/5/2025	2:00:00 AM	0.04
10/5/2025	2:15:00 AM	0.04
10/5/2025	2:30:00 AM	0.04
10/5/2025	2:45:00 AM	0.04
10/5/2025	3:00:00 AM	0.04
10/5/2025	3:15:00 AM	0.04
10/5/2025	3:30:00 AM	0.04
10/5/2025	3:45:00 AM	0.04
10/5/2025	4:00:00 AM	0.04
10/5/2025	4:15:00 AM	0.04
10/5/2025	4:30:00 AM	0.04
10/5/2025	4:45:00 AM	0.04
10/5/2025	5:00:00 AM	0.04
10/5/2025	5:15:00 AM	0.04
10/5/2025	5:30:00 AM	0.04
10/5/2025	5:45:00 AM	0.04
10/5/2025	6:00:00 AM	0.04
10/5/2025	6:15:00 AM	0.04
10/5/2025	6:30:00 AM	0.05
10/5/2025	6:45:00 AM	0.04
10/5/2025	7:00:00 AM	0.05
10/5/2025	7:15:00 AM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
10/5/2025	7:30:00 AM	0.05
10/5/2025	7:45:00 AM	0.05
10/5/2025	8:00:00 AM	0.05
10/5/2025	8:15:00 AM	0.05
10/5/2025	8:30:00 AM	0.05
10/5/2025	8:45:00 AM	0.05
10/5/2025	9:00:00 AM	0.05
10/5/2025	9:15:00 AM	0.05
10/5/2025	9:30:00 AM	0.05
10/5/2025	9:45:00 AM	0.05
10/5/2025	10:00:00 AM	0.05
10/5/2025	10:15:00 AM	0.05
10/5/2025	10:30:00 AM	0.05
10/5/2025	10:45:00 AM	0.05
10/5/2025	11:00:00 AM	0.05
10/5/2025	11:15:00 AM	0.05
10/5/2025	11:30:00 AM	0.05
10/5/2025	11:45:00 AM	0.05
10/5/2025	12:00:00 PM	0.05
10/5/2025	12:15:00 PM	0.05
10/5/2025	12:30:00 PM	0.05
10/5/2025	12:45:00 PM	0.05
10/5/2025	1:00:00 PM	0.05
10/5/2025	1:15:00 PM	0.05
10/5/2025	1:30:00 PM	0.04
10/5/2025	1:45:00 PM	0.05
10/5/2025	2:00:00 PM	0.05
10/5/2025	2:15:00 PM	0.05
10/5/2025	2:30:00 PM	0.05
10/5/2025	2:45:00 PM	0.05
10/5/2025	3:00:00 PM	0.04
10/5/2025	3:15:00 PM	0.05
10/5/2025	3:30:00 PM	0.05
10/5/2025	3:45:00 PM	0.04
10/5/2025	4:00:00 PM	0.05
10/5/2025	4:15:00 PM	0.04
10/5/2025	4:30:00 PM	0.04
10/5/2025	4:45:00 PM	0.04
10/5/2025	5:00:00 PM	0.05
10/5/2025	5:15:00 PM	0.04
10/5/2025	5:30:00 PM	0.04
10/5/2025	5:45:00 PM	0.04
10/5/2025	6:00:00 PM	0.04
10/5/2025	6:15:00 PM	0.04
10/5/2025	6:30:00 PM	0.04
10/5/2025	6:45:00 PM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
10/5/2025	7:00:00 PM	0.04
10/5/2025	7:15:00 PM	0.04
10/5/2025	7:30:00 PM	0.04
10/5/2025	7:45:00 PM	0.04
10/5/2025	8:00:00 PM	0.04
10/5/2025	8:15:00 PM	0.04
10/5/2025	8:30:00 PM	0.04
10/5/2025	8:45:00 PM	0.04
10/5/2025	9:00:00 PM	0.04
10/5/2025	9:15:00 PM	0.04
10/5/2025	9:30:00 PM	0.05
10/5/2025	9:45:00 PM	0.05
10/5/2025	10:00:00 PM	0.05
10/5/2025	10:15:00 PM	0.05
10/5/2025	10:30:00 PM	0.05
10/5/2025	10:45:00 PM	0.05
10/5/2025	11:00:00 PM	0.05
10/5/2025	11:15:00 PM	0.05
10/5/2025	11:30:00 PM	0.05
10/5/2025	11:45:00 PM	0.05
10/6/2025	12:00:00 AM	0.05
10/6/2025	12:15:00 AM	0.05
10/6/2025	12:30:00 AM	0.05
10/6/2025	12:45:00 AM	0.05
10/6/2025	1:00:00 AM	0.05
10/6/2025	1:15:00 AM	0.05
10/6/2025	1:30:00 AM	0.05
10/6/2025	1:45:00 AM	0.05
10/6/2025	2:00:00 AM	0.05
10/6/2025	2:15:00 AM	0.05
10/6/2025	2:30:00 AM	0.05
10/6/2025	2:45:00 AM	0.05
10/6/2025	3:00:00 AM	0.05
10/6/2025	3:15:00 AM	0.05
10/6/2025	3:30:00 AM	0.05
10/6/2025	3:45:00 AM	0.05
10/6/2025	4:00:00 AM	0.05
10/6/2025	4:15:00 AM	0.05
10/6/2025	4:30:00 AM	0.05
10/6/2025	4:45:00 AM	0.05
10/6/2025	5:00:00 AM	0.05
10/6/2025	5:15:00 AM	0.06
10/6/2025	5:30:00 AM	0.06
10/6/2025	5:45:00 AM	0.06
10/6/2025	6:00:00 AM	0.06
10/6/2025	6:15:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/6/2025	6:30:00 AM	0.06
10/6/2025	6:45:00 AM	0.06
10/6/2025	7:00:00 AM	0.05
10/6/2025	7:15:00 AM	0.06
10/6/2025	7:30:00 AM	0.06
10/6/2025	7:45:00 AM	0.06
10/6/2025	8:00:00 AM	0.06
10/6/2025	8:15:00 AM	0.05
10/6/2025	8:30:00 AM	0.05
10/6/2025	8:45:00 AM	0.05
10/6/2025	9:00:00 AM	0.05
10/6/2025	9:15:00 AM	0.05
10/6/2025	9:30:00 AM	0.05
10/6/2025	9:45:00 AM	0.05
10/6/2025	10:00:00 AM	0.05
10/6/2025	10:15:00 AM	0.05
10/6/2025	10:30:00 AM	0.05
10/6/2025	10:45:00 AM	0.05
10/6/2025	11:00:00 AM	0.05
10/6/2025	11:15:00 AM	0.05
10/6/2025	11:30:00 AM	0.05
10/6/2025	11:45:00 AM	0.05
10/6/2025	12:00:00 PM	0.05
10/6/2025	12:15:00 PM	0.05
10/6/2025	12:30:00 PM	0.05
10/6/2025	12:45:00 PM	0.05
10/6/2025	1:00:00 PM	0.05
10/6/2025	1:15:00 PM	0.05
10/6/2025	1:30:00 PM	0.05
10/6/2025	1:45:00 PM	0.04
10/6/2025	2:00:00 PM	0.04
10/6/2025	2:15:00 PM	0.04
10/6/2025	2:30:00 PM	0.04
10/6/2025	2:45:00 PM	0.04
10/6/2025	3:00:00 PM	0.04
10/6/2025	3:15:00 PM	0.04
10/6/2025	3:30:00 PM	0.04
10/6/2025	3:45:00 PM	0.04
10/6/2025	4:00:00 PM	0.04
10/6/2025	4:15:00 PM	0.04
10/6/2025	4:30:00 PM	0.04
10/6/2025	4:45:00 PM	0.04
10/6/2025	5:00:00 PM	0.04
10/6/2025	5:15:00 PM	0.04
10/6/2025	5:30:00 PM	0.04
10/6/2025	5:45:00 PM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
10/6/2025	6:00:00 PM	0.04
10/6/2025	6:15:00 PM	0.04
10/6/2025	6:30:00 PM	0.04
10/6/2025	6:45:00 PM	0.04
10/6/2025	7:00:00 PM	0.04
10/6/2025	7:15:00 PM	0.04
10/6/2025	7:30:00 PM	0.04
10/6/2025	7:45:00 PM	0.04
10/6/2025	8:00:00 PM	0.04
10/6/2025	8:15:00 PM	0.04
10/6/2025	8:30:00 PM	0.04
10/6/2025	8:45:00 PM	0.05
10/6/2025	9:00:00 PM	0.05
10/6/2025	9:15:00 PM	0.05
10/6/2025	9:30:00 PM	0.05
10/6/2025	9:45:00 PM	0.05
10/6/2025	10:00:00 PM	0.05
10/6/2025	10:15:00 PM	0.05
10/6/2025	10:30:00 PM	0.05
10/6/2025	10:45:00 PM	0.05
10/6/2025	11:00:00 PM	0.05
10/6/2025	11:15:00 PM	0.05
10/6/2025	11:30:00 PM	0.05
10/6/2025	11:45:00 PM	0.05
10/7/2025	12:00:00 AM	0.05
10/7/2025	12:15:00 AM	0.05
10/7/2025	12:30:00 AM	0.05
10/7/2025	12:45:00 AM	0.05
10/7/2025	1:00:00 AM	0.05
10/7/2025	1:15:00 AM	0.06
10/7/2025	1:30:00 AM	0.06
10/7/2025	1:45:00 AM	0.06
10/7/2025	2:00:00 AM	0.06
10/7/2025	2:15:00 AM	0.06
10/7/2025	2:30:00 AM	0.06
10/7/2025	2:45:00 AM	0.06
10/7/2025	3:00:00 AM	0.06
10/7/2025	3:15:00 AM	0.06
10/7/2025	3:30:00 AM	0.06
10/7/2025	3:45:00 AM	0.06
10/7/2025	4:00:00 AM	0.06
10/7/2025	4:15:00 AM	0.06
10/7/2025	4:30:00 AM	0.06
10/7/2025	4:45:00 AM	0.06
10/7/2025	5:00:00 AM	0.06
10/7/2025	5:15:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/7/2025	5:30:00 AM	0.06
10/7/2025	5:45:00 AM	0.06
10/7/2025	6:00:00 AM	0.06
10/7/2025	6:15:00 AM	0.06
10/7/2025	6:30:00 AM	0.06
10/7/2025	6:45:00 AM	0.06
10/7/2025	7:00:00 AM	0.06
10/7/2025	7:15:00 AM	0.06
10/7/2025	7:30:00 AM	0.06
10/7/2025	7:45:00 AM	0.06
10/7/2025	8:00:00 AM	0.06
10/7/2025	8:15:00 AM	0.06
10/7/2025	8:30:00 AM	0.06
10/7/2025	8:45:00 AM	0.06
10/7/2025	9:00:00 AM	0.06
10/7/2025	9:15:00 AM	0.06
10/7/2025	9:30:00 AM	0.06
10/7/2025	9:45:00 AM	0.06
10/7/2025	10:00:00 AM	0.06
10/7/2025	10:15:00 AM	0.06
10/7/2025	10:30:00 AM	0.06
10/7/2025	10:45:00 AM	0.06
10/7/2025	11:00:00 AM	0.06
10/7/2025	11:15:00 AM	0.06
10/7/2025	11:30:00 AM	0.06
10/7/2025	11:45:00 AM	0.06
10/7/2025	12:00:00 PM	0.06
10/7/2025	12:15:00 PM	0.06
10/7/2025	12:30:00 PM	0.06
10/7/2025	12:45:00 PM	0.05
10/7/2025	1:00:00 PM	0.05
10/7/2025	1:15:00 PM	0.05
10/7/2025	1:30:00 PM	0.05
10/7/2025	1:45:00 PM	0.05
10/7/2025	2:00:00 PM	0.05
10/7/2025	2:15:00 PM	0.05
10/7/2025	2:30:00 PM	0.05
10/7/2025	2:45:00 PM	0.05
10/7/2025	3:00:00 PM	0.05
10/7/2025	3:15:00 PM	0.05
10/7/2025	3:30:00 PM	0.05
10/7/2025	3:45:00 PM	0.05
10/7/2025	4:00:00 PM	0.05
10/7/2025	4:15:00 PM	0.05
10/7/2025	4:30:00 PM	0.04
10/7/2025	4:45:00 PM	0.04

Georges Ditch Return Gage

DATE	TIME	GAGE
10/7/2025	5:00:00 PM	0.04
10/7/2025	5:15:00 PM	0.04
10/7/2025	5:30:00 PM	0.04
10/7/2025	5:45:00 PM	0.04
10/7/2025	6:00:00 PM	0.04
10/7/2025	6:15:00 PM	0.04
10/7/2025	6:30:00 PM	0.04
10/7/2025	6:45:00 PM	0.04
10/7/2025	7:00:00 PM	0.04
10/7/2025	7:15:00 PM	0.04
10/7/2025	7:30:00 PM	0.04
10/7/2025	7:45:00 PM	0.04
10/7/2025	8:00:00 PM	0.04
10/7/2025	8:15:00 PM	0.04
10/7/2025	8:30:00 PM	0.04
10/7/2025	8:45:00 PM	0.04
10/7/2025	9:00:00 PM	0.04
10/7/2025	9:15:00 PM	0.05
10/7/2025	9:30:00 PM	0.05
10/7/2025	9:45:00 PM	0.05
10/7/2025	10:00:00 PM	0.05
10/7/2025	10:15:00 PM	0.05
10/7/2025	10:30:00 PM	0.05
10/7/2025	10:45:00 PM	0.05
10/7/2025	11:00:00 PM	0.05
10/7/2025	11:15:00 PM	0.05
10/7/2025	11:30:00 PM	0.05
10/7/2025	11:45:00 PM	0.05
10/8/2025	12:00:00 AM	0.05
10/8/2025	12:15:00 AM	0.06
10/8/2025	12:30:00 AM	0.06
10/8/2025	12:45:00 AM	0.06
10/8/2025	1:00:00 AM	0.06
10/8/2025	1:15:00 AM	0.06
10/8/2025	1:30:00 AM	0.06
10/8/2025	1:45:00 AM	0.06
10/8/2025	2:00:00 AM	0.06
10/8/2025	2:15:00 AM	0.06
10/8/2025	2:30:00 AM	0.06
10/8/2025	2:45:00 AM	0.06
10/8/2025	3:00:00 AM	0.06
10/8/2025	3:15:00 AM	0.06
10/8/2025	3:30:00 AM	0.06
10/8/2025	3:45:00 AM	0.06
10/8/2025	4:00:00 AM	0.06
10/8/2025	4:15:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/8/2025	4:30:00 AM	0.06
10/8/2025	4:45:00 AM	0.06
10/8/2025	5:00:00 AM	0.06
10/8/2025	5:15:00 AM	0.06
10/8/2025	5:30:00 AM	0.07
10/8/2025	5:45:00 AM	0.06
10/8/2025	6:00:00 AM	.
10/8/2025	6:15:00 AM	.
10/8/2025	6:30:00 AM	.
10/8/2025	6:45:00 AM	.
10/8/2025	7:00:00 AM	.
10/8/2025	7:15:00 AM	0.07
10/8/2025	7:30:00 AM	0.07
10/8/2025	7:45:00 AM	0.07
10/8/2025	8:00:00 AM	0.07
10/8/2025	8:15:00 AM	0.07
10/8/2025	8:30:00 AM	0.07
10/8/2025	8:45:00 AM	0.07
10/8/2025	9:00:00 AM	0.07
10/8/2025	9:15:00 AM	0.07
10/8/2025	9:30:00 AM	0.07
10/8/2025	9:45:00 AM	0.07
10/8/2025	10:00:00 AM	0.07
10/8/2025	10:15:00 AM	0.07
10/8/2025	10:30:00 AM	0.07
10/8/2025	10:45:00 AM	0.07
10/8/2025	11:00:00 AM	0.07
10/8/2025	11:15:00 AM	0.07
10/8/2025	11:30:00 AM	0.07
10/8/2025	11:45:00 AM	0.07
10/8/2025	12:00:00 PM	0.07
10/8/2025	12:15:00 PM	0.07
10/8/2025	12:30:00 PM	0.07
10/8/2025	12:45:00 PM	0.07
10/8/2025	1:00:00 PM	0.07
10/8/2025	1:15:00 PM	0.07
10/8/2025	1:30:00 PM	0.07
10/8/2025	1:45:00 PM	0.07
10/8/2025	2:00:00 PM	0.07
10/8/2025	2:15:00 PM	0.07
10/8/2025	2:30:00 PM	0.07
10/8/2025	2:45:00 PM	0.07
10/8/2025	3:00:00 PM	0.07
10/8/2025	3:15:00 PM	0.07
10/8/2025	3:30:00 PM	0.07
10/8/2025	3:45:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
10/8/2025	4:00:00 PM	0.07
10/8/2025	4:15:00 PM	0.07
10/8/2025	4:30:00 PM	0.07
10/8/2025	4:45:00 PM	0.07
10/8/2025	5:00:00 PM	0.07
10/8/2025	5:15:00 PM	0.06
10/8/2025	5:30:00 PM	0.06
10/8/2025	5:45:00 PM	0.07
10/8/2025	6:00:00 PM	0.07
10/8/2025	6:15:00 PM	0.07
10/8/2025	6:30:00 PM	0.07
10/8/2025	6:45:00 PM	0.07
10/8/2025	7:00:00 PM	0.07
10/8/2025	7:15:00 PM	0.07
10/8/2025	7:30:00 PM	0.07
10/8/2025	7:45:00 PM	0.07
10/8/2025	8:00:00 PM	0.07
10/8/2025	8:15:00 PM	0.07
10/8/2025	8:30:00 PM	0.07
10/8/2025	8:45:00 PM	0.07
10/8/2025	9:00:00 PM	0.07
10/8/2025	9:15:00 PM	0.07
10/8/2025	9:30:00 PM	0.07
10/8/2025	9:45:00 PM	0.07
10/8/2025	10:00:00 PM	0.07
10/8/2025	10:15:00 PM	0.07
10/8/2025	10:30:00 PM	0.07
10/8/2025	10:45:00 PM	0.07
10/8/2025	11:00:00 PM	0.07
10/8/2025	11:15:00 PM	0.07
10/8/2025	11:30:00 PM	0.07
10/8/2025	11:45:00 PM	0.07
10/9/2025	12:00:00 AM	0.07
10/9/2025	12:15:00 AM	0.07
10/9/2025	12:30:00 AM	0.07
10/9/2025	12:45:00 AM	0.07
10/9/2025	1:00:00 AM	0.07
10/9/2025	1:15:00 AM	0.07
10/9/2025	1:30:00 AM	0.07
10/9/2025	1:45:00 AM	0.07
10/9/2025	2:00:00 AM	0.07
10/9/2025	2:15:00 AM	0.07
10/9/2025	2:30:00 AM	0.07
10/9/2025	2:45:00 AM	0.07
10/9/2025	3:00:00 AM	0.07
10/9/2025	3:15:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
10/9/2025	3:30:00 AM	0.07
10/9/2025	3:45:00 AM	0.07
10/9/2025	4:00:00 AM	0.07
10/9/2025	4:15:00 AM	0.07
10/9/2025	4:30:00 AM	0.07
10/9/2025	4:45:00 AM	0.07
10/9/2025	5:00:00 AM	0.07
10/9/2025	5:15:00 AM	0.07
10/9/2025	5:30:00 AM	0.07
10/9/2025	5:45:00 AM	0.07
10/9/2025	6:00:00 AM	0.07
10/9/2025	6:15:00 AM	0.07
10/9/2025	6:30:00 AM	0.07
10/9/2025	6:45:00 AM	0.07
10/9/2025	7:00:00 AM	0.07
10/9/2025	7:15:00 AM	0.07
10/9/2025	7:30:00 AM	0.07
10/9/2025	7:45:00 AM	0.07
10/9/2025	8:00:00 AM	0.07
10/9/2025	8:15:00 AM	0.07
10/9/2025	8:30:00 AM	0.07
10/9/2025	8:45:00 AM	0.07
10/9/2025	9:00:00 AM	0.07
10/9/2025	9:15:00 AM	0.07
10/9/2025	9:30:00 AM	0.07
10/9/2025	9:45:00 AM	0.07
10/9/2025	10:00:00 AM	0.07
10/9/2025	10:15:00 AM	0.07
10/9/2025	10:30:00 AM	0.07
10/9/2025	10:45:00 AM	0.07
10/9/2025	11:00:00 AM	0.07
10/9/2025	11:15:00 AM	0.07
10/9/2025	11:30:00 AM	0.07
10/9/2025	11:45:00 AM	0.07
10/9/2025	12:00:00 PM	0.07
10/9/2025	12:15:00 PM	0.06
10/9/2025	12:30:00 PM	0.06
10/9/2025	12:45:00 PM	0.06
10/9/2025	1:00:00 PM	0.06
10/9/2025	1:15:00 PM	0.06
10/9/2025	1:30:00 PM	0.06
10/9/2025	1:45:00 PM	0.06
10/9/2025	2:00:00 PM	0.06
10/9/2025	2:15:00 PM	0.06
10/9/2025	2:30:00 PM	0.06
10/9/2025	2:45:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/9/2025	3:00:00 PM	0.06
10/9/2025	3:15:00 PM	0.06
10/9/2025	3:30:00 PM	0.06
10/9/2025	3:45:00 PM	0.06
10/9/2025	4:00:00 PM	0.06
10/9/2025	4:15:00 PM	0.06
10/9/2025	4:30:00 PM	0.06
10/9/2025	4:45:00 PM	0.06
10/9/2025	5:00:00 PM	0.06
10/9/2025	5:15:00 PM	0.06
10/9/2025	5:30:00 PM	0.06
10/9/2025	5:45:00 PM	0.06
10/9/2025	6:00:00 PM	0.06
10/9/2025	6:15:00 PM	0.06
10/9/2025	6:30:00 PM	0.06
10/9/2025	6:45:00 PM	0.06
10/9/2025	7:00:00 PM	0.06
10/9/2025	7:15:00 PM	0.06
10/9/2025	7:30:00 PM	0.06
10/9/2025	7:45:00 PM	0.06
10/9/2025	8:00:00 PM	0.06
10/9/2025	8:15:00 PM	0.06
10/9/2025	8:30:00 PM	0.06
10/9/2025	8:45:00 PM	0.06
10/9/2025	9:00:00 PM	0.06
10/9/2025	9:15:00 PM	0.06
10/9/2025	9:30:00 PM	0.06
10/9/2025	9:45:00 PM	0.06
10/9/2025	10:00:00 PM	0.06
10/9/2025	10:15:00 PM	0.06
10/9/2025	10:30:00 PM	0.06
10/9/2025	10:45:00 PM	0.06
10/9/2025	11:00:00 PM	0.06
10/9/2025	11:15:00 PM	0.06
10/9/2025	11:30:00 PM	0.06
10/9/2025	11:45:00 PM	0.06
10/10/2025	12:00:00 AM	0.06
10/10/2025	12:15:00 AM	0.06
10/10/2025	12:30:00 AM	0.06
10/10/2025	12:45:00 AM	0.06
10/10/2025	1:00:00 AM	0.06
10/10/2025	1:15:00 AM	0.06
10/10/2025	1:30:00 AM	0.06
10/10/2025	1:45:00 AM	0.06
10/10/2025	2:00:00 AM	0.06
10/10/2025	2:15:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/10/2025	2:30:00 AM	0.07
10/10/2025	2:45:00 AM	0.07
10/10/2025	3:00:00 AM	0.07
10/10/2025	3:15:00 AM	0.07
10/10/2025	3:30:00 AM	0.07
10/10/2025	3:45:00 AM	0.07
10/10/2025	4:00:00 AM	0.07
10/10/2025	4:15:00 AM	0.07
10/10/2025	4:30:00 AM	0.07
10/10/2025	4:45:00 AM	0.07
10/10/2025	5:00:00 AM	0.07
10/10/2025	5:15:00 AM	0.07
10/10/2025	5:30:00 AM	0.07
10/10/2025	5:45:00 AM	0.07
10/10/2025	6:00:00 AM	0.07
10/10/2025	6:15:00 AM	0.07
10/10/2025	6:30:00 AM	0.07
10/10/2025	6:45:00 AM	0.07
10/10/2025	7:00:00 AM	0.07
10/10/2025	7:15:00 AM	0.07
10/10/2025	7:30:00 AM	0.07
10/10/2025	7:45:00 AM	0.07
10/10/2025	8:00:00 AM	0.07
10/10/2025	8:15:00 AM	0.07
10/10/2025	8:30:00 AM	0.07
10/10/2025	8:45:00 AM	0.07
10/10/2025	9:00:00 AM	0.07
10/10/2025	9:15:00 AM	0.07
10/10/2025	9:30:00 AM	0.07
10/10/2025	9:45:00 AM	0.07
10/10/2025	10:00:00 AM	0.07
10/10/2025	10:15:00 AM	0.07
10/10/2025	10:30:00 AM	0.07
10/10/2025	10:45:00 AM	0.07
10/10/2025	11:00:00 AM	0.07
10/10/2025	11:15:00 AM	0.07
10/10/2025	11:30:00 AM	0.07
10/10/2025	11:45:00 AM	0.07
10/10/2025	12:00:00 PM	0.07
10/10/2025	12:15:00 PM	0.07
10/10/2025	12:30:00 PM	0.07
10/10/2025	12:45:00 PM	0.07
10/10/2025	1:00:00 PM	0.07
10/10/2025	1:15:00 PM	0.07
10/10/2025	1:30:00 PM	0.07
10/10/2025	1:45:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
10/10/2025	2:00:00 PM	0.07
10/10/2025	2:15:00 PM	0.07
10/10/2025	2:30:00 PM	0.07
10/10/2025	2:45:00 PM	0.07
10/10/2025	3:00:00 PM	0.07
10/10/2025	3:15:00 PM	0.07
10/10/2025	3:30:00 PM	0.07
10/10/2025	3:45:00 PM	0.07
10/10/2025	4:00:00 PM	0.07
10/10/2025	4:15:00 PM	0.07
10/10/2025	4:30:00 PM	0.07
10/10/2025	4:45:00 PM	0.07
10/10/2025	5:00:00 PM	0.07
10/10/2025	5:15:00 PM	0.07
10/10/2025	5:30:00 PM	0.07
10/10/2025	5:45:00 PM	0.07
10/10/2025	6:00:00 PM	0.07
10/10/2025	6:15:00 PM	0.07
10/10/2025	6:30:00 PM	0.07
10/10/2025	6:45:00 PM	0.07
10/10/2025	7:00:00 PM	0.07
10/10/2025	7:15:00 PM	0.07
10/10/2025	7:30:00 PM	0.07
10/10/2025	7:45:00 PM	0.07
10/10/2025	8:00:00 PM	0.07
10/10/2025	8:15:00 PM	0.07
10/10/2025	8:30:00 PM	0.07
10/10/2025	8:45:00 PM	0.07
10/10/2025	9:00:00 PM	0.07
10/10/2025	9:15:00 PM	0.07
10/10/2025	9:30:00 PM	0.07
10/10/2025	9:45:00 PM	0.07
10/10/2025	10:00:00 PM	0.07
10/10/2025	10:15:00 PM	0.07
10/10/2025	10:30:00 PM	0.07
10/10/2025	10:45:00 PM	0.07
10/10/2025	11:00:00 PM	0.07
10/10/2025	11:15:00 PM	0.07
10/10/2025	11:30:00 PM	0.07
10/10/2025	11:45:00 PM	0.07
10/11/2025	12:00:00 AM	0.07
10/11/2025	12:15:00 AM	0.07
10/11/2025	12:30:00 AM	0.07
10/11/2025	12:45:00 AM	0.07
10/11/2025	1:00:00 AM	0.07
10/11/2025	1:15:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
10/11/2025	1:30:00 AM	0.07
10/11/2025	1:45:00 AM	0.07
10/11/2025	2:00:00 AM	0.07
10/11/2025	2:15:00 AM	0.07
10/11/2025	2:30:00 AM	0.07
10/11/2025	2:45:00 AM	0.07
10/11/2025	3:00:00 AM	0.07
10/11/2025	3:15:00 AM	0.07
10/11/2025	3:30:00 AM	0.07
10/11/2025	3:45:00 AM	0.07
10/11/2025	4:00:00 AM	0.07
10/11/2025	4:15:00 AM	0.07
10/11/2025	4:30:00 AM	0.07
10/11/2025	4:45:00 AM	0.07
10/11/2025	5:00:00 AM	0.07
10/11/2025	5:15:00 AM	0.07
10/11/2025	5:30:00 AM	0.07
10/11/2025	5:45:00 AM	0.07
10/11/2025	6:00:00 AM	0.07
10/11/2025	6:15:00 AM	0.07
10/11/2025	6:30:00 AM	0.07
10/11/2025	6:45:00 AM	0.07
10/11/2025	7:00:00 AM	0.07
10/11/2025	7:15:00 AM	0.07
10/11/2025	7:30:00 AM	0.07
10/11/2025	7:45:00 AM	0.07
10/11/2025	8:00:00 AM	0.07
10/11/2025	8:15:00 AM	0.07
10/11/2025	8:30:00 AM	0.07
10/11/2025	8:45:00 AM	0.07
10/11/2025	9:00:00 AM	0.07
10/11/2025	9:15:00 AM	0.07
10/11/2025	9:30:00 AM	0.07
10/11/2025	9:45:00 AM	0.07
10/11/2025	10:00:00 AM	0.07
10/11/2025	10:15:00 AM	0.07
10/11/2025	10:30:00 AM	0.07
10/11/2025	10:45:00 AM	0.07
10/11/2025	11:00:00 AM	0.07
10/11/2025	11:15:00 AM	0.07
10/11/2025	11:30:00 AM	0.07
10/11/2025	11:45:00 AM	0.07
10/11/2025	12:00:00 PM	0.07
10/11/2025	12:15:00 PM	0.07
10/11/2025	12:30:00 PM	0.07
10/11/2025	12:45:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
10/11/2025	1:00:00 PM	0.07
10/11/2025	1:15:00 PM	0.07
10/11/2025	1:30:00 PM	0.07
10/11/2025	1:45:00 PM	0.07
10/11/2025	2:00:00 PM	0.07
10/11/2025	2:15:00 PM	0.07
10/11/2025	2:30:00 PM	0.07
10/11/2025	2:45:00 PM	0.07
10/11/2025	3:00:00 PM	0.07
10/11/2025	3:15:00 PM	0.07
10/11/2025	3:30:00 PM	0.07
10/11/2025	3:45:00 PM	0.07
10/11/2025	4:00:00 PM	0.07
10/11/2025	4:15:00 PM	0.07
10/11/2025	4:30:00 PM	0.07
10/11/2025	4:45:00 PM	0.07
10/11/2025	5:00:00 PM	0.07
10/11/2025	5:15:00 PM	0.07
10/11/2025	5:30:00 PM	0.07
10/11/2025	5:45:00 PM	0.06
10/11/2025	6:00:00 PM	0.07
10/11/2025	6:15:00 PM	0.07
10/11/2025	6:30:00 PM	0.06
10/11/2025	6:45:00 PM	0.07
10/11/2025	7:00:00 PM	0.07
10/11/2025	7:15:00 PM	0.07
10/11/2025	7:30:00 PM	0.07
10/11/2025	7:45:00 PM	0.07
10/11/2025	8:00:00 PM	0.07
10/11/2025	8:15:00 PM	0.07
10/11/2025	8:30:00 PM	0.07
10/11/2025	8:45:00 PM	0.07
10/11/2025	9:00:00 PM	0.07
10/11/2025	9:15:00 PM	0.07
10/11/2025	9:30:00 PM	0.07
10/11/2025	9:45:00 PM	0.07
10/11/2025	10:00:00 PM	0.07
10/11/2025	10:15:00 PM	0.07
10/11/2025	10:30:00 PM	0.07
10/11/2025	10:45:00 PM	0.07
10/11/2025	11:00:00 PM	0.07
10/11/2025	11:15:00 PM	0.07
10/11/2025	11:30:00 PM	0.07
10/11/2025	11:45:00 PM	0.07
10/12/2025	12:00:00 AM	0.07
10/12/2025	12:15:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
10/12/2025	12:30:00 AM	0.07
10/12/2025	12:45:00 AM	0.07
10/12/2025	1:00:00 AM	0.07
10/12/2025	1:15:00 AM	0.07
10/12/2025	1:30:00 AM	0.07
10/12/2025	1:45:00 AM	0.07
10/12/2025	2:00:00 AM	0.07
10/12/2025	2:15:00 AM	0.07
10/12/2025	2:30:00 AM	0.07
10/12/2025	2:45:00 AM	0.07
10/12/2025	3:00:00 AM	0.07
10/12/2025	3:15:00 AM	0.07
10/12/2025	3:30:00 AM	0.07
10/12/2025	3:45:00 AM	0.07
10/12/2025	4:00:00 AM	0.07
10/12/2025	4:15:00 AM	0.07
10/12/2025	4:30:00 AM	0.07
10/12/2025	4:45:00 AM	0.07
10/12/2025	5:00:00 AM	0.07
10/12/2025	5:15:00 AM	0.07
10/12/2025	5:30:00 AM	0.07
10/12/2025	5:45:00 AM	0.07
10/12/2025	6:00:00 AM	0.07
10/12/2025	6:15:00 AM	0.07
10/12/2025	6:30:00 AM	0.07
10/12/2025	6:45:00 AM	0.07
10/12/2025	7:00:00 AM	0.07
10/12/2025	7:15:00 AM	0.07
10/12/2025	7:30:00 AM	0.07
10/12/2025	7:45:00 AM	0.07
10/12/2025	8:00:00 AM	0.07
10/12/2025	8:15:00 AM	0.07
10/12/2025	8:30:00 AM	0.07
10/12/2025	8:45:00 AM	0.07
10/12/2025	9:00:00 AM	0.07
10/12/2025	9:15:00 AM	0.07
10/12/2025	9:30:00 AM	0.07
10/12/2025	9:45:00 AM	0.07
10/12/2025	10:00:00 AM	0.07
10/12/2025	10:15:00 AM	0.07
10/12/2025	10:30:00 AM	0.07
10/12/2025	10:45:00 AM	0.07
10/12/2025	11:00:00 AM	0.06
10/12/2025	11:15:00 AM	0.06
10/12/2025	11:30:00 AM	0.06
10/12/2025	11:45:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/12/2025	12:00:00 PM	0.06
10/12/2025	12:15:00 PM	0.06
10/12/2025	12:30:00 PM	0.06
10/12/2025	12:45:00 PM	0.06
10/12/2025	1:00:00 PM	0.06
10/12/2025	1:15:00 PM	0.06
10/12/2025	1:30:00 PM	0.06
10/12/2025	1:45:00 PM	0.06
10/12/2025	2:00:00 PM	0.06
10/12/2025	2:15:00 PM	0.06
10/12/2025	2:30:00 PM	0.06
10/12/2025	2:45:00 PM	0.06
10/12/2025	3:00:00 PM	0.06
10/12/2025	3:15:00 PM	0.05
10/12/2025	3:30:00 PM	0.05
10/12/2025	3:45:00 PM	0.05
10/12/2025	4:00:00 PM	0.05
10/12/2025	4:15:00 PM	0.05
10/12/2025	4:30:00 PM	0.05
10/12/2025	4:45:00 PM	0.05
10/12/2025	5:00:00 PM	0.05
10/12/2025	5:15:00 PM	0.05
10/12/2025	5:30:00 PM	0.05
10/12/2025	5:45:00 PM	0.05
10/12/2025	6:00:00 PM	0.05
10/12/2025	6:15:00 PM	0.05
10/12/2025	6:30:00 PM	0.05
10/12/2025	6:45:00 PM	0.05
10/12/2025	7:00:00 PM	0.05
10/12/2025	7:15:00 PM	0.05
10/12/2025	7:30:00 PM	0.05
10/12/2025	7:45:00 PM	0.05
10/12/2025	8:00:00 PM	0.05
10/12/2025	8:15:00 PM	0.05
10/12/2025	8:30:00 PM	0.05
10/12/2025	8:45:00 PM	0.05
10/12/2025	9:00:00 PM	0.05
10/12/2025	9:15:00 PM	0.05
10/12/2025	9:30:00 PM	0.05
10/12/2025	9:45:00 PM	0.05
10/12/2025	10:00:00 PM	0.05
10/12/2025	10:15:00 PM	0.05
10/12/2025	10:30:00 PM	0.05
10/12/2025	10:45:00 PM	0.05
10/12/2025	11:00:00 PM	0.05
10/12/2025	11:15:00 PM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
10/12/2025	11:30:00 PM	0.05
10/12/2025	11:45:00 PM	0.05
10/13/2025	12:00:00 AM	0.05
10/13/2025	12:15:00 AM	0.05
10/13/2025	12:30:00 AM	0.05
10/13/2025	12:45:00 AM	0.05
10/13/2025	1:00:00 AM	0.05
10/13/2025	1:15:00 AM	0.05
10/13/2025	1:30:00 AM	0.05
10/13/2025	1:45:00 AM	0.05
10/13/2025	2:00:00 AM	0.05
10/13/2025	2:15:00 AM	0.05
10/13/2025	2:30:00 AM	0.05
10/13/2025	2:45:00 AM	0.05
10/13/2025	3:00:00 AM	0.05
10/13/2025	3:15:00 AM	0.05
10/13/2025	3:30:00 AM	0.05
10/13/2025	3:45:00 AM	0.05
10/13/2025	4:00:00 AM	0.05
10/13/2025	4:15:00 AM	0.05
10/13/2025	4:30:00 AM	0.05
10/13/2025	4:45:00 AM	0.05
10/13/2025	5:00:00 AM	0.05
10/13/2025	5:15:00 AM	0.05
10/13/2025	5:30:00 AM	0.05
10/13/2025	5:45:00 AM	0.06
10/13/2025	6:00:00 AM	0.06
10/13/2025	6:15:00 AM	0.05
10/13/2025	6:30:00 AM	0.06
10/13/2025	6:45:00 AM	0.05
10/13/2025	7:00:00 AM	0.05
10/13/2025	7:15:00 AM	0.06
10/13/2025	7:30:00 AM	0.06
10/13/2025	7:45:00 AM	0.05
10/13/2025	8:00:00 AM	0.05
10/13/2025	8:15:00 AM	0.05
10/13/2025	8:30:00 AM	0.05
10/13/2025	8:45:00 AM	0.05
10/13/2025	9:00:00 AM	0.05
10/13/2025	9:15:00 AM	0.06
10/13/2025	9:30:00 AM	0.06
10/13/2025	9:45:00 AM	0.06
10/13/2025	10:00:00 AM	0.06
10/13/2025	10:15:00 AM	0.06
10/13/2025	10:30:00 AM	0.06
10/13/2025	10:45:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/13/2025	11:00:00 AM	0.06
10/13/2025	11:15:00 AM	0.06
10/13/2025	11:30:00 AM	0.06
10/13/2025	11:45:00 AM	0.06
10/13/2025	12:00:00 PM	0.06
10/13/2025	12:15:00 PM	0.06
10/13/2025	12:30:00 PM	0.06
10/13/2025	12:45:00 PM	0.06
10/13/2025	1:00:00 PM	0.06
10/13/2025	1:15:00 PM	0.06
10/13/2025	1:30:00 PM	0.06
10/13/2025	1:45:00 PM	0.06
10/13/2025	2:00:00 PM	0.06
10/13/2025	2:15:00 PM	0.06
10/13/2025	2:30:00 PM	0.06
10/13/2025	2:45:00 PM	0.06
10/13/2025	3:00:00 PM	0.06
10/13/2025	3:15:00 PM	0.06
10/13/2025	3:30:00 PM	0.06
10/13/2025	3:45:00 PM	0.06
10/13/2025	4:00:00 PM	0.06
10/13/2025	4:15:00 PM	0.06
10/13/2025	4:30:00 PM	0.06
10/13/2025	4:45:00 PM	0.06
10/13/2025	5:00:00 PM	0.06
10/13/2025	5:15:00 PM	0.07
10/13/2025	5:30:00 PM	0.07
10/13/2025	5:45:00 PM	0.07
10/13/2025	6:00:00 PM	0.07
10/13/2025	6:15:00 PM	0.06
10/13/2025	6:30:00 PM	0.06
10/13/2025	6:45:00 PM	0.07
10/13/2025	7:00:00 PM	0.07
10/13/2025	7:15:00 PM	0.07
10/13/2025	7:30:00 PM	0.07
10/13/2025	7:45:00 PM	0.06
10/13/2025	8:00:00 PM	0.07
10/13/2025	8:15:00 PM	0.07
10/13/2025	8:30:00 PM	0.07
10/13/2025	8:45:00 PM	0.07
10/13/2025	9:00:00 PM	0.07
10/13/2025	9:15:00 PM	0.07
10/13/2025	9:30:00 PM	0.07
10/13/2025	9:45:00 PM	0.07
10/13/2025	10:00:00 PM	0.07
10/13/2025	10:15:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
10/13/2025	10:30:00 PM	0.07
10/13/2025	10:45:00 PM	0.07
10/13/2025	11:00:00 PM	0.07
10/13/2025	11:15:00 PM	0.07
10/13/2025	11:30:00 PM	0.07
10/13/2025	11:45:00 PM	0.07
10/14/2025	12:00:00 AM	0.07
10/14/2025	12:15:00 AM	0.07
10/14/2025	12:30:00 AM	0.07
10/14/2025	12:45:00 AM	0.07
10/14/2025	1:00:00 AM	0.07
10/14/2025	1:15:00 AM	0.07
10/14/2025	1:30:00 AM	0.07
10/14/2025	1:45:00 AM	0.07
10/14/2025	2:00:00 AM	0.07
10/14/2025	2:15:00 AM	0.07
10/14/2025	2:30:00 AM	0.07
10/14/2025	2:45:00 AM	0.07
10/14/2025	3:00:00 AM	0.07
10/14/2025	3:15:00 AM	0.07
10/14/2025	3:30:00 AM	0.07
10/14/2025	3:45:00 AM	0.07
10/14/2025	4:00:00 AM	0.07
10/14/2025	4:15:00 AM	0.07
10/14/2025	4:30:00 AM	0.07
10/14/2025	4:45:00 AM	0.07
10/14/2025	5:00:00 AM	0.07
10/14/2025	5:15:00 AM	0.07
10/14/2025	5:30:00 AM	0.07
10/14/2025	5:45:00 AM	0.07
10/14/2025	6:00:00 AM	0.07
10/14/2025	6:15:00 AM	0.07
10/14/2025	6:30:00 AM	0.07
10/14/2025	6:45:00 AM	0.07
10/14/2025	7:00:00 AM	0.07
10/14/2025	7:15:00 AM	0.07
10/14/2025	7:30:00 AM	0.07
10/14/2025	7:45:00 AM	0.07
10/14/2025	8:00:00 AM	0.07
10/14/2025	8:15:00 AM	0.07
10/14/2025	8:30:00 AM	0.07
10/14/2025	8:45:00 AM	0.07
10/14/2025	9:00:00 AM	0.07
10/14/2025	9:15:00 AM	0.07
10/14/2025	9:30:00 AM	0.07
10/14/2025	9:45:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
10/14/2025	10:00:00 AM	0.07
10/14/2025	10:15:00 AM	0.07
10/14/2025	10:30:00 AM	0.07
10/14/2025	10:45:00 AM	0.07
10/14/2025	11:00:00 AM	0.07
10/14/2025	11:15:00 AM	0.08
10/14/2025	11:30:00 AM	0.08
10/14/2025	11:45:00 AM	0.07
10/14/2025	12:00:00 PM	0.08
10/14/2025	12:15:00 PM	0.08
10/14/2025	12:30:00 PM	0.08
10/14/2025	12:45:00 PM	0.08
10/14/2025	1:00:00 PM	0.08
10/14/2025	1:15:00 PM	0.08
10/14/2025	1:30:00 PM	0.08
10/14/2025	1:45:00 PM	0.08
10/14/2025	2:00:00 PM	0.08
10/14/2025	2:15:00 PM	0.08
10/14/2025	2:30:00 PM	0.08
10/14/2025	2:45:00 PM	0.08
10/14/2025	3:00:00 PM	0.08
10/14/2025	3:15:00 PM	0.09
10/14/2025	3:30:00 PM	0.08
10/14/2025	3:45:00 PM	0.09
10/14/2025	4:00:00 PM	0.09
10/14/2025	4:15:00 PM	0.08
10/14/2025	4:30:00 PM	0.09
10/14/2025	4:45:00 PM	0.09
10/14/2025	5:00:00 PM	0.08
10/14/2025	5:15:00 PM	0.08
10/14/2025	5:30:00 PM	0.08
10/14/2025	5:45:00 PM	0.08
10/14/2025	6:00:00 PM	0.08
10/14/2025	6:15:00 PM	0.08
10/14/2025	6:30:00 PM	0.08
10/14/2025	6:45:00 PM	0.08
10/14/2025	7:00:00 PM	0.08
10/14/2025	7:15:00 PM	0.08
10/14/2025	7:30:00 PM	0.08
10/14/2025	7:45:00 PM	0.08
10/14/2025	8:00:00 PM	0.08
10/14/2025	8:15:00 PM	0.08
10/14/2025	8:30:00 PM	0.08
10/14/2025	8:45:00 PM	0.08
10/14/2025	9:00:00 PM	0.08
10/14/2025	9:15:00 PM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
10/14/2025	9:30:00 PM	0.08
10/14/2025	9:45:00 PM	0.08
10/14/2025	10:00:00 PM	0.08
10/14/2025	10:15:00 PM	0.08
10/14/2025	10:30:00 PM	0.08
10/14/2025	10:45:00 PM	0.08
10/14/2025	11:00:00 PM	0.08
10/14/2025	11:15:00 PM	0.08
10/14/2025	11:30:00 PM	0.08
10/14/2025	11:45:00 PM	0.08
10/15/2025	12:00:00 AM	0.08
10/15/2025	12:15:00 AM	0.08
10/15/2025	12:30:00 AM	0.08
10/15/2025	12:45:00 AM	0.08
10/15/2025	1:00:00 AM	0.08
10/15/2025	1:15:00 AM	0.08
10/15/2025	1:30:00 AM	0.08
10/15/2025	1:45:00 AM	0.08
10/15/2025	2:00:00 AM	0.08
10/15/2025	2:15:00 AM	0.08
10/15/2025	2:30:00 AM	0.08
10/15/2025	2:45:00 AM	0.08
10/15/2025	3:00:00 AM	0.08
10/15/2025	3:15:00 AM	0.08
10/15/2025	3:30:00 AM	0.08
10/15/2025	3:45:00 AM	0.08
10/15/2025	4:00:00 AM	0.08
10/15/2025	4:15:00 AM	0.08
10/15/2025	4:30:00 AM	0.07
10/15/2025	4:45:00 AM	0.07
10/15/2025	5:00:00 AM	0.07
10/15/2025	5:15:00 AM	0.07
10/15/2025	5:30:00 AM	0.07
10/15/2025	5:45:00 AM	0.07
10/15/2025	6:00:00 AM	0.07
10/15/2025	6:15:00 AM	0.07
10/15/2025	6:30:00 AM	0.07
10/15/2025	6:45:00 AM	0.07
10/15/2025	7:00:00 AM	0.07
10/15/2025	7:15:00 AM	0.07
10/15/2025	7:30:00 AM	0.07
10/15/2025	7:45:00 AM	0.07
10/15/2025	8:00:00 AM	0.07
10/15/2025	8:15:00 AM	0.07
10/15/2025	8:30:00 AM	0.07
10/15/2025	8:45:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
10/15/2025	9:00:00 AM	0.07
10/15/2025	9:15:00 AM	0.07
10/15/2025	9:30:00 AM	0.07
10/15/2025	9:45:00 AM	0.07
10/15/2025	10:00:00 AM	0.07
10/15/2025	10:15:00 AM	0.07
10/15/2025	10:30:00 AM	0.07
10/15/2025	10:45:00 AM	0.07
10/15/2025	11:00:00 AM	0.07
10/15/2025	11:15:00 AM	0.07
10/15/2025	11:30:00 AM	0.07
10/15/2025	11:45:00 AM	0.07
10/15/2025	12:00:00 PM	0.07
10/15/2025	12:15:00 PM	0.07
10/15/2025	12:30:00 PM	0.07
10/15/2025	12:45:00 PM	0.07
10/15/2025	1:00:00 PM	0.07
10/15/2025	1:15:00 PM	0.07
10/15/2025	1:30:00 PM	0.07
10/15/2025	1:45:00 PM	0.07
10/15/2025	2:00:00 PM	0.07
10/15/2025	2:15:00 PM	0.07
10/15/2025	2:30:00 PM	0.07
10/15/2025	2:45:00 PM	0.07
10/15/2025	3:00:00 PM	0.07
10/15/2025	3:15:00 PM	0.07
10/15/2025	3:30:00 PM	0.07
10/15/2025	3:45:00 PM	0.07
10/15/2025	4:00:00 PM	0.07
10/15/2025	4:15:00 PM	0.07
10/15/2025	4:30:00 PM	0.07
10/15/2025	4:45:00 PM	0.07
10/15/2025	5:00:00 PM	0.07
10/15/2025	5:15:00 PM	0.07
10/15/2025	5:30:00 PM	0.07
10/15/2025	5:45:00 PM	0.07
10/15/2025	6:00:00 PM	0.07
10/15/2025	6:15:00 PM	0.07
10/15/2025	6:30:00 PM	0.07
10/15/2025	6:45:00 PM	0.07
10/15/2025	7:00:00 PM	0.07
10/15/2025	7:15:00 PM	0.07
10/15/2025	7:30:00 PM	0.07
10/15/2025	7:45:00 PM	0.07
10/15/2025	8:00:00 PM	0.07
10/15/2025	8:15:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
10/15/2025	8:30:00 PM	0.07
10/15/2025	8:45:00 PM	0.07
10/15/2025	9:00:00 PM	0.07
10/15/2025	9:15:00 PM	0.07
10/15/2025	9:30:00 PM	0.07
10/15/2025	9:45:00 PM	0.07
10/15/2025	10:00:00 PM	0.07
10/15/2025	10:15:00 PM	0.07
10/15/2025	10:30:00 PM	0.07
10/15/2025	10:45:00 PM	0.07
10/15/2025	11:00:00 PM	0.07
10/15/2025	11:15:00 PM	0.07
10/15/2025	11:30:00 PM	0.07
10/15/2025	11:45:00 PM	0.07
10/16/2025	12:00:00 AM	0.07
10/16/2025	12:15:00 AM	0.07
10/16/2025	12:30:00 AM	0.07
10/16/2025	12:45:00 AM	0.07
10/16/2025	1:00:00 AM	0.07
10/16/2025	1:15:00 AM	0.07
10/16/2025	1:30:00 AM	0.07
10/16/2025	1:45:00 AM	0.07
10/16/2025	2:00:00 AM	0.07
10/16/2025	2:15:00 AM	0.07
10/16/2025	2:30:00 AM	0.07
10/16/2025	2:45:00 AM	0.07
10/16/2025	3:00:00 AM	0.07
10/16/2025	3:15:00 AM	0.07
10/16/2025	3:30:00 AM	0.07
10/16/2025	3:45:00 AM	0.07
10/16/2025	4:00:00 AM	0.07
10/16/2025	4:15:00 AM	0.07
10/16/2025	4:30:00 AM	0.07
10/16/2025	4:45:00 AM	0.07
10/16/2025	5:00:00 AM	0.07
10/16/2025	5:15:00 AM	0.07
10/16/2025	5:30:00 AM	0.07
10/16/2025	5:45:00 AM	0.07
10/16/2025	6:00:00 AM	0.07
10/16/2025	6:15:00 AM	0.07
10/16/2025	6:30:00 AM	0.07
10/16/2025	6:45:00 AM	0.07
10/16/2025	7:00:00 AM	0.07
10/16/2025	7:15:00 AM	0.07
10/16/2025	7:30:00 AM	0.07
10/16/2025	7:45:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
10/16/2025	8:00:00 AM	0.07
10/16/2025	8:15:00 AM	0.07
10/16/2025	8:30:00 AM	0.07
10/16/2025	8:45:00 AM	0.07
10/16/2025	9:00:00 AM	0.07
10/16/2025	9:15:00 AM	0.07
10/16/2025	9:30:00 AM	0.07
10/16/2025	9:45:00 AM	0.07
10/16/2025	10:00:00 AM	0.07
10/16/2025	10:15:00 AM	0.07
10/16/2025	10:30:00 AM	0.07
10/16/2025	10:45:00 AM	0.07
10/16/2025	11:00:00 AM	0.07
10/16/2025	11:15:00 AM	0.07
10/16/2025	11:30:00 AM	0.07
10/16/2025	11:45:00 AM	0.07
10/16/2025	12:00:00 PM	0.07
10/16/2025	12:15:00 PM	0.07
10/16/2025	12:30:00 PM	0.07
10/16/2025	12:45:00 PM	0.07
10/16/2025	1:00:00 PM	0.07
10/16/2025	1:15:00 PM	0.07
10/16/2025	1:30:00 PM	0.07
10/16/2025	1:45:00 PM	0.07
10/16/2025	2:00:00 PM	0.07
10/16/2025	2:15:00 PM	0.07
10/16/2025	2:30:00 PM	0.07
10/16/2025	2:45:00 PM	0.06
10/16/2025	3:00:00 PM	0.06
10/16/2025	3:15:00 PM	0.06
10/16/2025	3:30:00 PM	0.06
10/16/2025	3:45:00 PM	0.06
10/16/2025	4:00:00 PM	0.06
10/16/2025	4:15:00 PM	0.06
10/16/2025	4:30:00 PM	0.06
10/16/2025	4:45:00 PM	0.06
10/16/2025	5:00:00 PM	0.06
10/16/2025	5:15:00 PM	0.06
10/16/2025	5:30:00 PM	0.06
10/16/2025	5:45:00 PM	0.06
10/16/2025	6:00:00 PM	0.06
10/16/2025	6:15:00 PM	0.06
10/16/2025	6:30:00 PM	0.06
10/16/2025	6:45:00 PM	0.06
10/16/2025	7:00:00 PM	0.06
10/16/2025	7:15:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/16/2025	7:30:00 PM	0.06
10/16/2025	7:45:00 PM	0.06
10/16/2025	8:00:00 PM	0.06
10/16/2025	8:15:00 PM	0.06
10/16/2025	8:30:00 PM	0.06
10/16/2025	8:45:00 PM	0.06
10/16/2025	9:00:00 PM	0.06
10/16/2025	9:15:00 PM	0.06
10/16/2025	9:30:00 PM	0.06
10/16/2025	9:45:00 PM	0.06
10/16/2025	10:00:00 PM	0.06
10/16/2025	10:15:00 PM	0.06
10/16/2025	10:30:00 PM	0.06
10/16/2025	10:45:00 PM	0.06
10/16/2025	11:00:00 PM	0.06
10/16/2025	11:15:00 PM	0.06
10/16/2025	11:30:00 PM	0.06
10/16/2025	11:45:00 PM	0.06
10/17/2025	12:00:00 AM	0.06
10/17/2025	12:15:00 AM	0.06
10/17/2025	12:30:00 AM	0.05
10/17/2025	12:45:00 AM	0.05
10/17/2025	1:00:00 AM	0.05
10/17/2025	1:15:00 AM	0.05
10/17/2025	1:30:00 AM	0.05
10/17/2025	1:45:00 AM	0.06
10/17/2025	2:00:00 AM	0.06
10/17/2025	2:15:00 AM	0.06
10/17/2025	2:30:00 AM	0.06
10/17/2025	2:45:00 AM	0.06
10/17/2025	3:00:00 AM	0.06
10/17/2025	3:15:00 AM	0.06
10/17/2025	3:30:00 AM	0.06
10/17/2025	3:45:00 AM	0.06
10/17/2025	4:00:00 AM	0.06
10/17/2025	4:15:00 AM	0.06
10/17/2025	4:30:00 AM	0.06
10/17/2025	4:45:00 AM	0.06
10/17/2025	5:00:00 AM	0.06
10/17/2025	5:15:00 AM	0.06
10/17/2025	5:30:00 AM	0.06
10/17/2025	5:45:00 AM	0.06
10/17/2025	6:00:00 AM	0.06
10/17/2025	6:15:00 AM	0.06
10/17/2025	6:30:00 AM	0.06
10/17/2025	6:45:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/17/2025	7:00:00 AM	0.06
10/17/2025	7:15:00 AM	0.06
10/17/2025	7:30:00 AM	0.06
10/17/2025	7:45:00 AM	0.06
10/17/2025	8:00:00 AM	0.06
10/17/2025	8:15:00 AM	0.06
10/17/2025	8:30:00 AM	0.05
10/17/2025	8:45:00 AM	0.05
10/17/2025	9:00:00 AM	0.05
10/17/2025	9:15:00 AM	0.05
10/17/2025	9:30:00 AM	0.05
10/17/2025	9:45:00 AM	0.05
10/17/2025	10:00:00 AM	0.05
10/17/2025	10:15:00 AM	0.05
10/17/2025	10:30:00 AM	0.05
10/17/2025	10:45:00 AM	0.05
10/17/2025	11:00:00 AM	0.05
10/17/2025	11:15:00 AM	0.05
10/17/2025	11:30:00 AM	0.05
10/17/2025	11:45:00 AM	0.05
10/17/2025	12:00:00 PM	0.05
10/17/2025	12:15:00 PM	0.05
10/17/2025	12:30:00 PM	0.05
10/17/2025	12:45:00 PM	0.05
10/17/2025	1:00:00 PM	0.05
10/17/2025	1:15:00 PM	0.05
10/17/2025	1:30:00 PM	0.05
10/17/2025	1:45:00 PM	0.05
10/17/2025	2:00:00 PM	0.05
10/17/2025	2:15:00 PM	0.05
10/17/2025	2:30:00 PM	0.05
10/17/2025	2:45:00 PM	0.05
10/17/2025	3:00:00 PM	0.05
10/17/2025	3:15:00 PM	0.05
10/17/2025	3:30:00 PM	0.05
10/17/2025	3:45:00 PM	0.05
10/17/2025	4:00:00 PM	0.05
10/17/2025	4:15:00 PM	0.05
10/17/2025	4:30:00 PM	0.05
10/17/2025	4:45:00 PM	0.05
10/17/2025	5:00:00 PM	0.05
10/17/2025	5:15:00 PM	0.05
10/17/2025	5:30:00 PM	0.05
10/17/2025	5:45:00 PM	0.05
10/17/2025	6:00:00 PM	0.05
10/17/2025	6:15:00 PM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
10/17/2025	6:30:00 PM	0.05
10/17/2025	6:45:00 PM	0.05
10/17/2025	7:00:00 PM	0.05
10/17/2025	7:15:00 PM	0.05
10/17/2025	7:30:00 PM	0.05
10/17/2025	7:45:00 PM	0.05
10/17/2025	8:00:00 PM	0.05
10/17/2025	8:15:00 PM	0.05
10/17/2025	8:30:00 PM	0.05
10/17/2025	8:45:00 PM	0.05
10/17/2025	9:00:00 PM	0.05
10/17/2025	9:15:00 PM	0.05
10/17/2025	9:30:00 PM	0.05
10/17/2025	9:45:00 PM	0.05
10/17/2025	10:00:00 PM	0.05
10/17/2025	10:15:00 PM	0.05
10/17/2025	10:30:00 PM	0.05
10/17/2025	10:45:00 PM	0.05
10/17/2025	11:00:00 PM	0.05
10/17/2025	11:15:00 PM	0.05
10/17/2025	11:30:00 PM	0.05
10/17/2025	11:45:00 PM	0.05
10/18/2025	12:00:00 AM	0.05
10/18/2025	12:15:00 AM	0.05
10/18/2025	12:30:00 AM	0.05
10/18/2025	12:45:00 AM	0.05
10/18/2025	1:00:00 AM	0.05
10/18/2025	1:15:00 AM	0.05
10/18/2025	1:30:00 AM	0.05
10/18/2025	1:45:00 AM	0.05
10/18/2025	2:00:00 AM	0.05
10/18/2025	2:15:00 AM	0.05
10/18/2025	2:30:00 AM	0.05
10/18/2025	2:45:00 AM	0.05
10/18/2025	3:00:00 AM	0.05
10/18/2025	3:15:00 AM	0.05
10/18/2025	3:30:00 AM	0.05
10/18/2025	3:45:00 AM	0.05
10/18/2025	4:00:00 AM	0.05
10/18/2025	4:15:00 AM	0.05
10/18/2025	4:30:00 AM	0.05
10/18/2025	4:45:00 AM	0.06
10/18/2025	5:00:00 AM	0.06
10/18/2025	5:15:00 AM	0.06
10/18/2025	5:30:00 AM	0.06
10/18/2025	5:45:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/18/2025	6:00:00 AM	0.06
10/18/2025	6:15:00 AM	0.06
10/18/2025	6:30:00 AM	0.06
10/18/2025	6:45:00 AM	0.06
10/18/2025	7:00:00 AM	0.06
10/18/2025	7:15:00 AM	0.06
10/18/2025	7:30:00 AM	0.06
10/18/2025	7:45:00 AM	0.06
10/18/2025	8:00:00 AM	0.06
10/18/2025	8:15:00 AM	0.06
10/18/2025	8:30:00 AM	0.06
10/18/2025	8:45:00 AM	0.06
10/18/2025	9:00:00 AM	0.06
10/18/2025	9:15:00 AM	0.06
10/18/2025	9:30:00 AM	0.06
10/18/2025	9:45:00 AM	0.06
10/18/2025	10:00:00 AM	0.06
10/18/2025	10:15:00 AM	0.06
10/18/2025	10:30:00 AM	0.06
10/18/2025	10:45:00 AM	0.06
10/18/2025	11:00:00 AM	0.06
10/18/2025	11:15:00 AM	0.06
10/18/2025	11:30:00 AM	0.06
10/18/2025	11:45:00 AM	0.06
10/18/2025	12:00:00 PM	0.06
10/18/2025	12:15:00 PM	0.06
10/18/2025	12:30:00 PM	0.06
10/18/2025	12:45:00 PM	0.06
10/18/2025	1:00:00 PM	0.06
10/18/2025	1:15:00 PM	0.06
10/18/2025	1:30:00 PM	0.06
10/18/2025	1:45:00 PM	0.06
10/18/2025	2:00:00 PM	0.06
10/18/2025	2:15:00 PM	0.06
10/18/2025	2:30:00 PM	0.06
10/18/2025	2:45:00 PM	0.06
10/18/2025	3:00:00 PM	0.06
10/18/2025	3:15:00 PM	0.05
10/18/2025	3:30:00 PM	0.06
10/18/2025	3:45:00 PM	0.06
10/18/2025	4:00:00 PM	0.05
10/18/2025	4:15:00 PM	0.06
10/18/2025	4:30:00 PM	0.05
10/18/2025	4:45:00 PM	0.05
10/18/2025	5:00:00 PM	0.05
10/18/2025	5:15:00 PM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
10/18/2025	5:30:00 PM	0.05
10/18/2025	5:45:00 PM	0.05
10/18/2025	6:00:00 PM	0.05
10/18/2025	6:15:00 PM	0.05
10/18/2025	6:30:00 PM	0.05
10/18/2025	6:45:00 PM	0.05
10/18/2025	7:00:00 PM	0.05
10/18/2025	7:15:00 PM	0.05
10/18/2025	7:30:00 PM	0.05
10/18/2025	7:45:00 PM	0.05
10/18/2025	8:00:00 PM	0.05
10/18/2025	8:15:00 PM	0.05
10/18/2025	8:30:00 PM	0.05
10/18/2025	8:45:00 PM	0.05
10/18/2025	9:00:00 PM	0.05
10/18/2025	9:15:00 PM	0.05
10/18/2025	9:30:00 PM	0.05
10/18/2025	9:45:00 PM	0.05
10/18/2025	10:00:00 PM	0.05
10/18/2025	10:15:00 PM	0.05
10/18/2025	10:30:00 PM	0.05
10/18/2025	10:45:00 PM	0.05
10/18/2025	11:00:00 PM	0.05
10/18/2025	11:15:00 PM	0.05
10/18/2025	11:30:00 PM	0.05
10/18/2025	11:45:00 PM	0.05
10/19/2025	12:00:00 AM	0.05
10/19/2025	12:15:00 AM	0.05
10/19/2025	12:30:00 AM	0.05
10/19/2025	12:45:00 AM	0.05
10/19/2025	1:00:00 AM	0.05
10/19/2025	1:15:00 AM	0.05
10/19/2025	1:30:00 AM	0.05
10/19/2025	1:45:00 AM	0.05
10/19/2025	2:00:00 AM	0.05
10/19/2025	2:15:00 AM	0.05
10/19/2025	2:30:00 AM	0.05
10/19/2025	2:45:00 AM	0.05
10/19/2025	3:00:00 AM	0.05
10/19/2025	3:15:00 AM	0.05
10/19/2025	3:30:00 AM	0.05
10/19/2025	3:45:00 AM	0.05
10/19/2025	4:00:00 AM	0.05
10/19/2025	4:15:00 AM	0.05
10/19/2025	4:30:00 AM	0.05
10/19/2025	4:45:00 AM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
10/19/2025	5:00:00 AM	0.05
10/19/2025	5:15:00 AM	0.05
10/19/2025	5:30:00 AM	0.05
10/19/2025	5:45:00 AM	0.05
10/19/2025	6:00:00 AM	0.05
10/19/2025	6:15:00 AM	0.05
10/19/2025	6:30:00 AM	0.05
10/19/2025	6:45:00 AM	0.05
10/19/2025	7:00:00 AM	0.05
10/19/2025	7:15:00 AM	0.05
10/19/2025	7:30:00 AM	0.05
10/19/2025	7:45:00 AM	0.05
10/19/2025	8:00:00 AM	0.05
10/19/2025	8:15:00 AM	0.05
10/19/2025	8:30:00 AM	0.05
10/19/2025	8:45:00 AM	0.05
10/19/2025	9:00:00 AM	0.05
10/19/2025	9:15:00 AM	0.05
10/19/2025	9:30:00 AM	0.05
10/19/2025	9:45:00 AM	0.05
10/19/2025	10:00:00 AM	0.05
10/19/2025	10:15:00 AM	0.05
10/19/2025	10:30:00 AM	0.05
10/19/2025	10:45:00 AM	0.05
10/19/2025	11:00:00 AM	0.05
10/19/2025	11:15:00 AM	0.05
10/19/2025	11:30:00 AM	0.05
10/19/2025	11:45:00 AM	0.05
10/19/2025	12:00:00 PM	0.05
10/19/2025	12:15:00 PM	0.05
10/19/2025	12:30:00 PM	0.05
10/19/2025	12:45:00 PM	0.05
10/19/2025	1:00:00 PM	0.05
10/19/2025	1:15:00 PM	0.05
10/19/2025	1:30:00 PM	0.05
10/19/2025	1:45:00 PM	0.05
10/19/2025	2:00:00 PM	0.05
10/19/2025	2:15:00 PM	0.05
10/19/2025	2:30:00 PM	0.05
10/19/2025	2:45:00 PM	0.05
10/19/2025	3:00:00 PM	0.05
10/19/2025	3:15:00 PM	0.05
10/19/2025	3:30:00 PM	0.05
10/19/2025	3:45:00 PM	0.05
10/19/2025	4:00:00 PM	0.05
10/19/2025	4:15:00 PM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
10/19/2025	4:30:00 PM	0.05
10/19/2025	4:45:00 PM	0.05
10/19/2025	5:00:00 PM	0.05
10/19/2025	5:15:00 PM	0.05
10/19/2025	5:30:00 PM	0.05
10/19/2025	5:45:00 PM	0.05
10/19/2025	6:00:00 PM	0.05
10/19/2025	6:15:00 PM	0.05
10/19/2025	6:30:00 PM	0.05
10/19/2025	6:45:00 PM	0.05
10/19/2025	7:00:00 PM	0.05
10/19/2025	7:15:00 PM	0.05
10/19/2025	7:30:00 PM	0.05
10/19/2025	7:45:00 PM	0.05
10/19/2025	8:00:00 PM	0.05
10/19/2025	8:15:00 PM	0.05
10/19/2025	8:30:00 PM	0.05
10/19/2025	8:45:00 PM	0.05
10/19/2025	9:00:00 PM	0.05
10/19/2025	9:15:00 PM	0.05
10/19/2025	9:30:00 PM	0.05
10/19/2025	9:45:00 PM	0.05
10/19/2025	10:00:00 PM	0.05
10/19/2025	10:15:00 PM	0.05
10/19/2025	10:30:00 PM	0.05
10/19/2025	10:45:00 PM	0.05
10/19/2025	11:00:00 PM	0.05
10/19/2025	11:15:00 PM	0.05
10/19/2025	11:30:00 PM	0.05
10/19/2025	11:45:00 PM	0.05
10/20/2025	12:00:00 AM	0.05
10/20/2025	12:15:00 AM	0.05
10/20/2025	12:30:00 AM	0.05
10/20/2025	12:45:00 AM	0.05
10/20/2025	1:00:00 AM	0.05
10/20/2025	1:15:00 AM	0.05
10/20/2025	1:30:00 AM	0.05
10/20/2025	1:45:00 AM	0.05
10/20/2025	2:00:00 AM	0.05
10/20/2025	2:15:00 AM	0.05
10/20/2025	2:30:00 AM	0.05
10/20/2025	2:45:00 AM	0.05
10/20/2025	3:00:00 AM	0.05
10/20/2025	3:15:00 AM	0.05
10/20/2025	3:30:00 AM	0.05
10/20/2025	3:45:00 AM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
10/20/2025	4:00:00 AM	0.05
10/20/2025	4:15:00 AM	0.05
10/20/2025	4:30:00 AM	0.05
10/20/2025	4:45:00 AM	0.05
10/20/2025	5:00:00 AM	0.05
10/20/2025	5:15:00 AM	0.05
10/20/2025	5:30:00 AM	0.05
10/20/2025	5:45:00 AM	0.05
10/20/2025	6:00:00 AM	0.05
10/20/2025	6:15:00 AM	0.05
10/20/2025	6:30:00 AM	0.05
10/20/2025	6:45:00 AM	0.05
10/20/2025	7:00:00 AM	0.05
10/20/2025	7:15:00 AM	0.05
10/20/2025	7:30:00 AM	0.05
10/20/2025	7:45:00 AM	0.05
10/20/2025	8:00:00 AM	0.05
10/20/2025	8:15:00 AM	0.05
10/20/2025	8:30:00 AM	0.05
10/20/2025	8:45:00 AM	0.05
10/20/2025	9:00:00 AM	0.05
10/20/2025	9:15:00 AM	0.05
10/20/2025	9:30:00 AM	0.05
10/20/2025	9:45:00 AM	0.05
10/20/2025	10:00:00 AM	0.05
10/20/2025	10:15:00 AM	0.05
10/20/2025	10:30:00 AM	0.05
10/20/2025	10:45:00 AM	0.05
10/20/2025	11:00:00 AM	0.05
10/20/2025	11:15:00 AM	0.05
10/20/2025	11:30:00 AM	0.05
10/20/2025	11:45:00 AM	0.05
10/20/2025	12:00:00 PM	0.05
10/20/2025	12:15:00 PM	0.05
10/20/2025	12:30:00 PM	0.05
10/20/2025	12:45:00 PM	0.05
10/20/2025	1:00:00 PM	0.05
10/20/2025	1:15:00 PM	0.05
10/20/2025	1:30:00 PM	0.05
10/20/2025	1:45:00 PM	0.05
10/20/2025	2:00:00 PM	0.05
10/20/2025	2:15:00 PM	0.04
10/20/2025	2:30:00 PM	0.05
10/20/2025	2:45:00 PM	0.05
10/20/2025	3:00:00 PM	0.05
10/20/2025	3:15:00 PM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
10/20/2025	3:30:00 PM	0.05
10/20/2025	3:45:00 PM	0.05
10/20/2025	4:00:00 PM	0.05
10/20/2025	4:15:00 PM	0.05
10/20/2025	4:30:00 PM	0.05
10/20/2025	4:45:00 PM	0.05
10/20/2025	5:00:00 PM	0.05
10/20/2025	5:15:00 PM	0.06
10/20/2025	5:30:00 PM	0.05
10/20/2025	5:45:00 PM	0.06
10/20/2025	6:00:00 PM	0.06
10/20/2025	6:15:00 PM	0.06
10/20/2025	6:30:00 PM	0.06
10/20/2025	6:45:00 PM	0.06
10/20/2025	7:00:00 PM	0.05
10/20/2025	7:15:00 PM	0.06
10/20/2025	7:30:00 PM	0.06
10/20/2025	7:45:00 PM	0.06
10/20/2025	8:00:00 PM	0.06
10/20/2025	8:15:00 PM	0.06
10/20/2025	8:30:00 PM	0.06
10/20/2025	8:45:00 PM	0.06
10/20/2025	9:00:00 PM	0.06
10/20/2025	9:15:00 PM	0.06
10/20/2025	9:30:00 PM	0.06
10/20/2025	9:45:00 PM	0.06
10/20/2025	10:00:00 PM	0.06
10/20/2025	10:15:00 PM	0.06
10/20/2025	10:30:00 PM	0.06
10/20/2025	10:45:00 PM	0.06
10/20/2025	11:00:00 PM	0.06
10/20/2025	11:15:00 PM	0.06
10/20/2025	11:30:00 PM	0.06
10/20/2025	11:45:00 PM	0.06
10/21/2025	12:00:00 AM	0.06
10/21/2025	12:15:00 AM	0.06
10/21/2025	12:30:00 AM	0.06
10/21/2025	12:45:00 AM	0.06
10/21/2025	1:00:00 AM	0.06
10/21/2025	1:15:00 AM	0.06
10/21/2025	1:30:00 AM	0.06
10/21/2025	1:45:00 AM	0.06
10/21/2025	2:00:00 AM	0.06
10/21/2025	2:15:00 AM	0.06
10/21/2025	2:30:00 AM	0.06
10/21/2025	2:45:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/21/2025	3:00:00 AM	0.06
10/21/2025	3:15:00 AM	0.06
10/21/2025	3:30:00 AM	0.06
10/21/2025	3:45:00 AM	0.06
10/21/2025	4:00:00 AM	0.06
10/21/2025	4:15:00 AM	0.06
10/21/2025	4:30:00 AM	0.06
10/21/2025	4:45:00 AM	0.06
10/21/2025	5:00:00 AM	0.06
10/21/2025	5:15:00 AM	0.06
10/21/2025	5:30:00 AM	0.06
10/21/2025	5:45:00 AM	0.06
10/21/2025	6:00:00 AM	0.06
10/21/2025	6:15:00 AM	0.06
10/21/2025	6:30:00 AM	0.06
10/21/2025	6:45:00 AM	0.06
10/21/2025	7:00:00 AM	0.06
10/21/2025	7:15:00 AM	0.06
10/21/2025	7:30:00 AM	0.06
10/21/2025	7:45:00 AM	0.06
10/21/2025	8:00:00 AM	0.06
10/21/2025	8:15:00 AM	0.06
10/21/2025	8:30:00 AM	0.06
10/21/2025	8:45:00 AM	0.06
10/21/2025	9:00:00 AM	0.06
10/21/2025	9:15:00 AM	0.06
10/21/2025	9:30:00 AM	0.06
10/21/2025	9:45:00 AM	0.06
10/21/2025	10:00:00 AM	0.06
10/21/2025	10:15:00 AM	0.06
10/21/2025	10:30:00 AM	0.06
10/21/2025	10:45:00 AM	0.06
10/21/2025	11:00:00 AM	0.06
10/21/2025	11:15:00 AM	0.06
10/21/2025	11:30:00 AM	0.06
10/21/2025	11:45:00 AM	0.06
10/21/2025	12:00:00 PM	0.06
10/21/2025	12:15:00 PM	0.06
10/21/2025	12:30:00 PM	0.06
10/21/2025	12:45:00 PM	0.06
10/21/2025	1:00:00 PM	0.06
10/21/2025	1:15:00 PM	0.06
10/21/2025	1:30:00 PM	0.06
10/21/2025	1:45:00 PM	0.06
10/21/2025	2:00:00 PM	0.06
10/21/2025	2:15:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/21/2025	2:30:00 PM	0.06
10/21/2025	2:45:00 PM	0.06
10/21/2025	3:00:00 PM	0.06
10/21/2025	3:15:00 PM	0.06
10/21/2025	3:30:00 PM	0.06
10/21/2025	3:45:00 PM	0.06
10/21/2025	4:00:00 PM	0.06
10/21/2025	4:15:00 PM	0.06
10/21/2025	4:30:00 PM	0.06
10/21/2025	4:45:00 PM	0.06
10/21/2025	5:00:00 PM	0.06
10/21/2025	5:15:00 PM	0.06
10/21/2025	5:30:00 PM	0.06
10/21/2025	5:45:00 PM	0.06
10/21/2025	6:00:00 PM	0.06
10/21/2025	6:15:00 PM	0.06
10/21/2025	6:30:00 PM	0.06
10/21/2025	6:45:00 PM	0.06
10/21/2025	7:00:00 PM	0.06
10/21/2025	7:15:00 PM	0.06
10/21/2025	7:30:00 PM	0.06
10/21/2025	7:45:00 PM	0.06
10/21/2025	8:00:00 PM	0.06
10/21/2025	8:15:00 PM	0.06
10/21/2025	8:30:00 PM	0.06
10/21/2025	8:45:00 PM	0.06
10/21/2025	9:00:00 PM	0.06
10/21/2025	9:15:00 PM	0.06
10/21/2025	9:30:00 PM	0.06
10/21/2025	9:45:00 PM	0.06
10/21/2025	10:00:00 PM	0.06
10/21/2025	10:15:00 PM	0.06
10/21/2025	10:30:00 PM	0.06
10/21/2025	10:45:00 PM	0.06
10/21/2025	11:00:00 PM	0.06
10/21/2025	11:15:00 PM	0.06
10/21/2025	11:30:00 PM	0.06
10/21/2025	11:45:00 PM	0.06
10/22/2025	12:00:00 AM	0.06
10/22/2025	12:15:00 AM	0.06
10/22/2025	12:30:00 AM	0.06
10/22/2025	12:45:00 AM	0.06
10/22/2025	1:00:00 AM	0.06
10/22/2025	1:15:00 AM	0.06
10/22/2025	1:30:00 AM	0.06
10/22/2025	1:45:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/22/2025	2:00:00 AM	0.06
10/22/2025	2:15:00 AM	0.06
10/22/2025	2:30:00 AM	0.06
10/22/2025	2:45:00 AM	0.06
10/22/2025	3:00:00 AM	0.07
10/22/2025	3:15:00 AM	0.07
10/22/2025	3:30:00 AM	0.07
10/22/2025	3:45:00 AM	0.07
10/22/2025	4:00:00 AM	0.07
10/22/2025	4:15:00 AM	0.07
10/22/2025	4:30:00 AM	0.07
10/22/2025	4:45:00 AM	0.07
10/22/2025	5:00:00 AM	0.07
10/22/2025	5:15:00 AM	0.07
10/22/2025	5:30:00 AM	0.07
10/22/2025	5:45:00 AM	0.07
10/22/2025	6:00:00 AM	0.07
10/22/2025	6:15:00 AM	0.07
10/22/2025	6:30:00 AM	0.07
10/22/2025	6:45:00 AM	0.07
10/22/2025	7:00:00 AM	0.07
10/22/2025	7:15:00 AM	0.07
10/22/2025	7:30:00 AM	0.07
10/22/2025	7:45:00 AM	0.07
10/22/2025	8:00:00 AM	0.07
10/22/2025	8:15:00 AM	0.07
10/22/2025	8:30:00 AM	0.07
10/22/2025	8:45:00 AM	0.07
10/22/2025	9:00:00 AM	0.07
10/22/2025	9:15:00 AM	0.07
10/22/2025	9:30:00 AM	0.07
10/22/2025	9:45:00 AM	0.07
10/22/2025	10:00:00 AM	0.07
10/22/2025	10:15:00 AM	0.07
10/22/2025	10:30:00 AM	0.07
10/22/2025	10:45:00 AM	0.07
10/22/2025	11:00:00 AM	0.07
10/22/2025	11:15:00 AM	0.07
10/22/2025	11:30:00 AM	0.09
10/22/2025	11:45:00 AM	0.09
10/22/2025	12:00:00 PM	0.09
10/22/2025	12:15:00 PM	0.09
10/22/2025	12:30:00 PM	0.09
10/22/2025	12:45:00 PM	0.09
10/22/2025	1:00:00 PM	0.09
10/22/2025	1:15:00 PM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
10/22/2025	1:30:00 PM	0.09
10/22/2025	1:45:00 PM	0.09
10/22/2025	2:00:00 PM	0.09
10/22/2025	2:15:00 PM	0.09
10/22/2025	2:30:00 PM	0.09
10/22/2025	2:45:00 PM	0.09
10/22/2025	3:00:00 PM	0.09
10/22/2025	3:15:00 PM	0.09
10/22/2025	3:30:00 PM	0.09
10/22/2025	3:45:00 PM	0.09
10/22/2025	4:00:00 PM	0.09
10/22/2025	4:15:00 PM	0.09
10/22/2025	4:30:00 PM	0.09
10/22/2025	4:45:00 PM	0.09
10/22/2025	5:00:00 PM	0.09
10/22/2025	5:15:00 PM	0.09
10/22/2025	5:30:00 PM	0.09
10/22/2025	5:45:00 PM	0.09
10/22/2025	6:00:00 PM	0.09
10/22/2025	6:15:00 PM	0.09
10/22/2025	6:30:00 PM	0.09
10/22/2025	6:45:00 PM	0.09
10/22/2025	7:00:00 PM	0.09
10/22/2025	7:15:00 PM	0.09
10/22/2025	7:30:00 PM	0.09
10/22/2025	7:45:00 PM	0.09
10/22/2025	8:00:00 PM	0.09
10/22/2025	8:15:00 PM	0.09
10/22/2025	8:30:00 PM	0.09
10/22/2025	8:45:00 PM	0.09
10/22/2025	9:00:00 PM	0.09
10/22/2025	9:15:00 PM	0.09
10/22/2025	9:30:00 PM	0.09
10/22/2025	9:45:00 PM	0.09
10/22/2025	10:00:00 PM	0.09
10/22/2025	10:15:00 PM	0.09
10/22/2025	10:30:00 PM	0.09
10/22/2025	10:45:00 PM	0.09
10/22/2025	11:00:00 PM	0.09
10/22/2025	11:15:00 PM	0.09
10/22/2025	11:30:00 PM	0.09
10/22/2025	11:45:00 PM	0.09
10/23/2025	12:00:00 AM	0.09
10/23/2025	12:15:00 AM	0.09
10/23/2025	12:30:00 AM	0.09
10/23/2025	12:45:00 AM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
10/23/2025	1:00:00 AM	0.09
10/23/2025	1:15:00 AM	0.09
10/23/2025	1:30:00 AM	0.09
10/23/2025	1:45:00 AM	0.09
10/23/2025	2:00:00 AM	0.09
10/23/2025	2:15:00 AM	0.09
10/23/2025	2:30:00 AM	0.09
10/23/2025	2:45:00 AM	0.09
10/23/2025	3:00:00 AM	0.09
10/23/2025	3:15:00 AM	0.09
10/23/2025	3:30:00 AM	0.09
10/23/2025	3:45:00 AM	0.09
10/23/2025	4:00:00 AM	0.09
10/23/2025	4:15:00 AM	0.09
10/23/2025	4:30:00 AM	0.09
10/23/2025	4:45:00 AM	0.09
10/23/2025	5:00:00 AM	0.09
10/23/2025	5:15:00 AM	0.09
10/23/2025	5:30:00 AM	0.09
10/23/2025	5:45:00 AM	0.09
10/23/2025	6:00:00 AM	0.09
10/23/2025	6:15:00 AM	0.09
10/23/2025	6:30:00 AM	0.09
10/23/2025	6:45:00 AM	0.09
10/23/2025	7:00:00 AM	0.09
10/23/2025	7:15:00 AM	0.09
10/23/2025	7:30:00 AM	0.09
10/23/2025	7:45:00 AM	0.09
10/23/2025	8:00:00 AM	0.09
10/23/2025	8:15:00 AM	0.09
10/23/2025	8:30:00 AM	0.09
10/23/2025	8:45:00 AM	0.09
10/23/2025	9:00:00 AM	0.09
10/23/2025	9:15:00 AM	0.09
10/23/2025	9:30:00 AM	0.09
10/23/2025	9:45:00 AM	0.09
10/23/2025	10:00:00 AM	0.09
10/23/2025	10:15:00 AM	0.09
10/23/2025	10:30:00 AM	0.09
10/23/2025	10:45:00 AM	0.09
10/23/2025	11:00:00 AM	0.09
10/23/2025	11:15:00 AM	0.09
10/23/2025	11:30:00 AM	0.09
10/23/2025	11:45:00 AM	0.09
10/23/2025	12:00:00 PM	0.09
10/23/2025	12:15:00 PM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
10/23/2025	12:30:00 PM	0.09
10/23/2025	12:45:00 PM	0.09
10/23/2025	1:00:00 PM	0.09
10/23/2025	1:15:00 PM	0.09
10/23/2025	1:30:00 PM	0.09
10/23/2025	1:45:00 PM	0.09
10/23/2025	2:00:00 PM	0.09
10/23/2025	2:15:00 PM	0.09
10/23/2025	2:30:00 PM	0.09
10/23/2025	2:45:00 PM	0.09
10/23/2025	3:00:00 PM	0.09
10/23/2025	3:15:00 PM	0.09
10/23/2025	3:30:00 PM	0.09
10/23/2025	3:45:00 PM	0.09
10/23/2025	4:00:00 PM	0.09
10/23/2025	4:15:00 PM	0.09
10/23/2025	4:30:00 PM	0.09
10/23/2025	4:45:00 PM	0.09
10/23/2025	5:00:00 PM	0.09
10/23/2025	5:15:00 PM	0.09
10/23/2025	5:30:00 PM	0.09
10/23/2025	5:45:00 PM	0.09
10/23/2025	6:00:00 PM	0.09
10/23/2025	6:15:00 PM	0.09
10/23/2025	6:30:00 PM	0.09
10/23/2025	6:45:00 PM	0.09
10/23/2025	7:00:00 PM	0.09
10/23/2025	7:15:00 PM	0.09
10/23/2025	7:30:00 PM	0.09
10/23/2025	7:45:00 PM	0.09
10/23/2025	8:00:00 PM	0.09
10/23/2025	8:15:00 PM	0.09
10/23/2025	8:30:00 PM	0.09
10/23/2025	8:45:00 PM	0.09
10/23/2025	9:00:00 PM	0.09
10/23/2025	9:15:00 PM	0.09
10/23/2025	9:30:00 PM	0.09
10/23/2025	9:45:00 PM	0.09
10/23/2025	10:00:00 PM	0.09
10/23/2025	10:15:00 PM	0.09
10/23/2025	10:30:00 PM	0.09
10/23/2025	10:45:00 PM	0.09
10/23/2025	11:00:00 PM	0.09
10/23/2025	11:15:00 PM	0.09
10/23/2025	11:30:00 PM	0.09
10/23/2025	11:45:00 PM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
10/24/2025	12:00:00 AM	0.09
10/24/2025	12:15:00 AM	0.09
10/24/2025	12:30:00 AM	0.09
10/24/2025	12:45:00 AM	0.09
10/24/2025	1:00:00 AM	0.09
10/24/2025	1:15:00 AM	0.09
10/24/2025	1:30:00 AM	0.09
10/24/2025	1:45:00 AM	0.09
10/24/2025	2:00:00 AM	0.09
10/24/2025	2:15:00 AM	0.09
10/24/2025	2:30:00 AM	0.09
10/24/2025	2:45:00 AM	0.09
10/24/2025	3:00:00 AM	0.09
10/24/2025	3:15:00 AM	0.09
10/24/2025	3:30:00 AM	0.09
10/24/2025	3:45:00 AM	0.09
10/24/2025	4:00:00 AM	0.09
10/24/2025	4:15:00 AM	0.09
10/24/2025	4:30:00 AM	0.09
10/24/2025	4:45:00 AM	0.09
10/24/2025	5:00:00 AM	0.09
10/24/2025	5:15:00 AM	0.09
10/24/2025	5:30:00 AM	0.09
10/24/2025	5:45:00 AM	0.09
10/24/2025	6:00:00 AM	0.09
10/24/2025	6:15:00 AM	0.09
10/24/2025	6:30:00 AM	0.09
10/24/2025	6:45:00 AM	0.09
10/24/2025	7:00:00 AM	0.09
10/24/2025	7:15:00 AM	0.09
10/24/2025	7:30:00 AM	0.09
10/24/2025	7:45:00 AM	0.09
10/24/2025	8:00:00 AM	0.09
10/24/2025	8:15:00 AM	0.1
10/24/2025	8:30:00 AM	0.1
10/24/2025	8:45:00 AM	0.1
10/24/2025	9:00:00 AM	0.09
10/24/2025	9:15:00 AM	0.09
10/24/2025	9:30:00 AM	0.09
10/24/2025	9:45:00 AM	0.1
10/24/2025	10:00:00 AM	0.1
10/24/2025	10:15:00 AM	0.1
10/24/2025	10:30:00 AM	0.09
10/24/2025	10:45:00 AM	0.1
10/24/2025	11:00:00 AM	0.09
10/24/2025	11:15:00 AM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
10/24/2025	11:30:00 AM	0.09
10/24/2025	11:45:00 AM	0.09
10/24/2025	12:00:00 PM	0.09
10/24/2025	12:15:00 PM	0.09
10/24/2025	12:30:00 PM	0.09
10/24/2025	12:45:00 PM	0.09
10/24/2025	1:00:00 PM	0.09
10/24/2025	1:15:00 PM	0.09
10/24/2025	1:30:00 PM	0.09
10/24/2025	1:45:00 PM	0.09
10/24/2025	2:00:00 PM	0.09
10/24/2025	2:15:00 PM	0.09
10/24/2025	2:30:00 PM	0.09
10/24/2025	2:45:00 PM	0.09
10/24/2025	3:00:00 PM	0.1
10/24/2025	3:15:00 PM	0.1
10/24/2025	3:30:00 PM	0.1
10/24/2025	3:45:00 PM	0.1
10/24/2025	4:00:00 PM	0.1
10/24/2025	4:15:00 PM	0.1
10/24/2025	4:30:00 PM	0.1
10/24/2025	4:45:00 PM	0.1
10/24/2025	5:00:00 PM	0.1
10/24/2025	5:15:00 PM	0.1
10/24/2025	5:30:00 PM	0.1
10/24/2025	5:45:00 PM	0.1
10/24/2025	6:00:00 PM	0.1
10/24/2025	6:15:00 PM	0.1
10/24/2025	6:30:00 PM	0.1
10/24/2025	6:45:00 PM	0.1
10/24/2025	7:00:00 PM	0.1
10/24/2025	7:15:00 PM	0.1
10/24/2025	7:30:00 PM	0.1
10/24/2025	7:45:00 PM	0.1
10/24/2025	8:00:00 PM	0.1
10/24/2025	8:15:00 PM	0.1
10/24/2025	8:30:00 PM	0.1
10/24/2025	8:45:00 PM	0.1
10/24/2025	9:00:00 PM	0.09
10/24/2025	9:15:00 PM	0.1
10/24/2025	9:30:00 PM	0.1
10/24/2025	9:45:00 PM	0.1
10/24/2025	10:00:00 PM	0.09
10/24/2025	10:15:00 PM	0.1
10/24/2025	10:30:00 PM	0.1
10/24/2025	10:45:00 PM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
10/24/2025	11:00:00 PM	0.09
10/24/2025	11:15:00 PM	0.09
10/24/2025	11:30:00 PM	0.1
10/24/2025	11:45:00 PM	0.09
10/25/2025	12:00:00 AM	0.1
10/25/2025	12:15:00 AM	0.1
10/25/2025	12:30:00 AM	0.1
10/25/2025	12:45:00 AM	0.09
10/25/2025	1:00:00 AM	0.1
10/25/2025	1:15:00 AM	0.1
10/25/2025	1:30:00 AM	0.1
10/25/2025	1:45:00 AM	0.1
10/25/2025	2:00:00 AM	0.1
10/25/2025	2:15:00 AM	0.1
10/25/2025	2:30:00 AM	0.1
10/25/2025	2:45:00 AM	0.1
10/25/2025	3:00:00 AM	0.1
10/25/2025	3:15:00 AM	0.1
10/25/2025	3:30:00 AM	0.1
10/25/2025	3:45:00 AM	0.1
10/25/2025	4:00:00 AM	0.1
10/25/2025	4:15:00 AM	0.1
10/25/2025	4:30:00 AM	0.1
10/25/2025	4:45:00 AM	0.1
10/25/2025	5:00:00 AM	0.1
10/25/2025	5:15:00 AM	0.1
10/25/2025	5:30:00 AM	0.1
10/25/2025	5:45:00 AM	0.1
10/25/2025	6:00:00 AM	0.1
10/25/2025	6:15:00 AM	0.1
10/25/2025	6:30:00 AM	0.1
10/25/2025	6:45:00 AM	0.1
10/25/2025	7:00:00 AM	0.09
10/25/2025	7:15:00 AM	0.09
10/25/2025	7:30:00 AM	0.09
10/25/2025	7:45:00 AM	0.09
10/25/2025	8:00:00 AM	0.09
10/25/2025	8:15:00 AM	0.09
10/25/2025	8:30:00 AM	0.09
10/25/2025	8:45:00 AM	0.09
10/25/2025	9:00:00 AM	0.09
10/25/2025	9:15:00 AM	0.09
10/25/2025	9:30:00 AM	0.09
10/25/2025	9:45:00 AM	0.09
10/25/2025	10:00:00 AM	0.09
10/25/2025	10:15:00 AM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
10/25/2025	10:30:00 AM	0.09
10/25/2025	10:45:00 AM	0.09
10/25/2025	11:00:00 AM	0.09
10/25/2025	11:15:00 AM	0.09
10/25/2025	11:30:00 AM	0.09
10/25/2025	11:45:00 AM	0.09
10/25/2025	12:00:00 PM	0.09
10/25/2025	12:15:00 PM	0.09
10/25/2025	12:30:00 PM	0.09
10/25/2025	12:45:00 PM	0.09
10/25/2025	1:00:00 PM	0.09
10/25/2025	1:15:00 PM	0.09
10/25/2025	1:30:00 PM	0.09
10/25/2025	1:45:00 PM	0.09
10/25/2025	2:00:00 PM	0.09
10/25/2025	2:15:00 PM	0.09
10/25/2025	2:30:00 PM	0.09
10/25/2025	2:45:00 PM	0.09
10/25/2025	3:00:00 PM	0.09
10/25/2025	3:15:00 PM	0.1
10/25/2025	3:30:00 PM	0.1
10/25/2025	3:45:00 PM	0.1
10/25/2025	4:00:00 PM	0.1
10/25/2025	4:15:00 PM	0.1
10/25/2025	4:30:00 PM	0.1
10/25/2025	4:45:00 PM	0.1
10/25/2025	5:00:00 PM	0.1
10/25/2025	5:15:00 PM	0.1
10/25/2025	5:30:00 PM	0.1
10/25/2025	5:45:00 PM	0.1
10/25/2025	6:00:00 PM	0.1
10/25/2025	6:15:00 PM	0.1
10/25/2025	6:30:00 PM	0.1
10/25/2025	6:45:00 PM	0.1
10/25/2025	7:00:00 PM	0.09
10/25/2025	7:15:00 PM	0.09
10/25/2025	7:30:00 PM	0.09
10/25/2025	7:45:00 PM	0.09
10/25/2025	8:00:00 PM	0.09
10/25/2025	8:15:00 PM	0.09
10/25/2025	8:30:00 PM	0.09
10/25/2025	8:45:00 PM	0.09
10/25/2025	9:00:00 PM	0.09
10/25/2025	9:15:00 PM	0.09
10/25/2025	9:30:00 PM	0.09
10/25/2025	9:45:00 PM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
10/25/2025	10:00:00 PM	0.09
10/25/2025	10:15:00 PM	0.09
10/25/2025	10:30:00 PM	0.09
10/25/2025	10:45:00 PM	0.09
10/25/2025	11:00:00 PM	0.09
10/25/2025	11:15:00 PM	0.09
10/25/2025	11:30:00 PM	0.09
10/25/2025	11:45:00 PM	0.09
10/26/2025	12:00:00 AM	0.09
10/26/2025	12:15:00 AM	0.09
10/26/2025	12:30:00 AM	0.09
10/26/2025	12:45:00 AM	0.09
10/26/2025	1:00:00 AM	0.09
10/26/2025	1:15:00 AM	0.09
10/26/2025	1:30:00 AM	0.09
10/26/2025	1:45:00 AM	0.09
10/26/2025	2:00:00 AM	0.09
10/26/2025	2:15:00 AM	0.09
10/26/2025	2:30:00 AM	0.09
10/26/2025	2:45:00 AM	0.09
10/26/2025	3:00:00 AM	0.09
10/26/2025	3:15:00 AM	0.09
10/26/2025	3:30:00 AM	0.09
10/26/2025	3:45:00 AM	0.09
10/26/2025	4:00:00 AM	0.09
10/26/2025	4:15:00 AM	0.09
10/26/2025	4:30:00 AM	0.09
10/26/2025	4:45:00 AM	0.09
10/26/2025	5:00:00 AM	0.09
10/26/2025	5:15:00 AM	0.09
10/26/2025	5:30:00 AM	0.09
10/26/2025	5:45:00 AM	0.09
10/26/2025	6:00:00 AM	0.09
10/26/2025	6:15:00 AM	0.09
10/26/2025	6:30:00 AM	0.09
10/26/2025	6:45:00 AM	0.09
10/26/2025	7:00:00 AM	0.09
10/26/2025	7:15:00 AM	0.09
10/26/2025	7:30:00 AM	0.09
10/26/2025	7:45:00 AM	0.08
10/26/2025	8:00:00 AM	0.08
10/26/2025	8:15:00 AM	0.08
10/26/2025	8:30:00 AM	0.08
10/26/2025	8:45:00 AM	0.08
10/26/2025	9:00:00 AM	0.08
10/26/2025	9:15:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
10/26/2025	9:30:00 AM	0.08
10/26/2025	9:45:00 AM	0.08
10/26/2025	10:00:00 AM	0.08
10/26/2025	10:15:00 AM	0.08
10/26/2025	10:30:00 AM	0.08
10/26/2025	10:45:00 AM	0.08
10/26/2025	11:00:00 AM	0.08
10/26/2025	11:15:00 AM	0.08
10/26/2025	11:30:00 AM	0.08
10/26/2025	11:45:00 AM	0.08
10/26/2025	12:00:00 PM	0.08
10/26/2025	12:15:00 PM	0.08
10/26/2025	12:30:00 PM	0.08
10/26/2025	12:45:00 PM	0.08
10/26/2025	1:00:00 PM	0.08
10/26/2025	1:15:00 PM	0.07
10/26/2025	1:30:00 PM	0.07
10/26/2025	1:45:00 PM	0.07
10/26/2025	2:00:00 PM	0.07
10/26/2025	2:15:00 PM	0.07
10/26/2025	2:30:00 PM	0.07
10/26/2025	2:45:00 PM	0.07
10/26/2025	3:00:00 PM	0.07
10/26/2025	3:15:00 PM	0.07
10/26/2025	3:30:00 PM	0.07
10/26/2025	3:45:00 PM	0.07
10/26/2025	4:00:00 PM	0.07
10/26/2025	4:15:00 PM	0.06
10/26/2025	4:30:00 PM	0.06
10/26/2025	4:45:00 PM	0.06
10/26/2025	5:00:00 PM	0.06
10/26/2025	5:15:00 PM	0.06
10/26/2025	5:30:00 PM	0.06
10/26/2025	5:45:00 PM	0.06
10/26/2025	6:00:00 PM	0.06
10/26/2025	6:15:00 PM	0.06
10/26/2025	6:30:00 PM	0.06
10/26/2025	6:45:00 PM	0.06
10/26/2025	7:00:00 PM	0.06
10/26/2025	7:15:00 PM	0.06
10/26/2025	7:30:00 PM	0.06
10/26/2025	7:45:00 PM	0.06
10/26/2025	8:00:00 PM	0.06
10/26/2025	8:15:00 PM	0.06
10/26/2025	8:30:00 PM	0.06
10/26/2025	8:45:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/26/2025	9:00:00 PM	0.07
10/26/2025	9:15:00 PM	0.07
10/26/2025	9:30:00 PM	0.07
10/26/2025	9:45:00 PM	0.07
10/26/2025	10:00:00 PM	0.07
10/26/2025	10:15:00 PM	0.07
10/26/2025	10:30:00 PM	0.07
10/26/2025	10:45:00 PM	0.07
10/26/2025	11:00:00 PM	0.07
10/26/2025	11:15:00 PM	0.07
10/26/2025	11:30:00 PM	0.07
10/26/2025	11:45:00 PM	0.07
10/27/2025	12:00:00 AM	0.07
10/27/2025	12:15:00 AM	0.07
10/27/2025	12:30:00 AM	0.07
10/27/2025	12:45:00 AM	0.07
10/27/2025	1:00:00 AM	0.07
10/27/2025	1:15:00 AM	0.07
10/27/2025	1:30:00 AM	0.07
10/27/2025	1:45:00 AM	0.07
10/27/2025	2:00:00 AM	0.07
10/27/2025	2:15:00 AM	0.07
10/27/2025	2:30:00 AM	0.07
10/27/2025	2:45:00 AM	0.07
10/27/2025	3:00:00 AM	0.07
10/27/2025	3:15:00 AM	0.07
10/27/2025	3:30:00 AM	0.07
10/27/2025	3:45:00 AM	0.07
10/27/2025	4:00:00 AM	0.07
10/27/2025	4:15:00 AM	0.07
10/27/2025	4:30:00 AM	0.07
10/27/2025	4:45:00 AM	0.07
10/27/2025	5:00:00 AM	0.07
10/27/2025	5:15:00 AM	0.07
10/27/2025	5:30:00 AM	0.07
10/27/2025	5:45:00 AM	0.07
10/27/2025	6:00:00 AM	0.07
10/27/2025	6:15:00 AM	0.07
10/27/2025	6:30:00 AM	0.07
10/27/2025	6:45:00 AM	0.07
10/27/2025	7:00:00 AM	0.07
10/27/2025	7:15:00 AM	0.07
10/27/2025	7:30:00 AM	0.07
10/27/2025	7:45:00 AM	0.07
10/27/2025	8:00:00 AM	0.07
10/27/2025	8:15:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
10/27/2025	8:30:00 AM	0.07
10/27/2025	8:45:00 AM	0.07
10/27/2025	9:00:00 AM	0.07
10/27/2025	9:15:00 AM	0.07
10/27/2025	9:30:00 AM	0.07
10/27/2025	9:45:00 AM	0.07
10/27/2025	10:00:00 AM	0.07
10/27/2025	10:15:00 AM	0.07
10/27/2025	10:30:00 AM	0.07
10/27/2025	10:45:00 AM	0.07
10/27/2025	11:00:00 AM	0.07
10/27/2025	11:15:00 AM	0.07
10/27/2025	11:30:00 AM	0.07
10/27/2025	11:45:00 AM	0.07
10/27/2025	12:00:00 PM	0.07
10/27/2025	12:15:00 PM	0.07
10/27/2025	12:30:00 PM	0.07
10/27/2025	12:45:00 PM	0.07
10/27/2025	1:00:00 PM	0.06
10/27/2025	1:15:00 PM	0.06
10/27/2025	1:30:00 PM	0.07
10/27/2025	1:45:00 PM	0.06
10/27/2025	2:00:00 PM	0.06
10/27/2025	2:15:00 PM	0.06
10/27/2025	2:30:00 PM	0.06
10/27/2025	2:45:00 PM	0.06
10/27/2025	3:00:00 PM	0.06
10/27/2025	3:15:00 PM	0.06
10/27/2025	3:30:00 PM	0.06
10/27/2025	3:45:00 PM	0.06
10/27/2025	4:00:00 PM	0.06
10/27/2025	4:15:00 PM	0.06
10/27/2025	4:30:00 PM	0.06
10/27/2025	4:45:00 PM	0.06
10/27/2025	5:00:00 PM	0.06
10/27/2025	5:15:00 PM	0.06
10/27/2025	5:30:00 PM	0.06
10/27/2025	5:45:00 PM	0.06
10/27/2025	6:00:00 PM	0.06
10/27/2025	6:15:00 PM	0.06
10/27/2025	6:30:00 PM	0.06
10/27/2025	6:45:00 PM	0.06
10/27/2025	7:00:00 PM	0.06
10/27/2025	7:15:00 PM	0.06
10/27/2025	7:30:00 PM	0.06
10/27/2025	7:45:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/27/2025	8:00:00 PM	0.06
10/27/2025	8:15:00 PM	0.06
10/27/2025	8:30:00 PM	0.06
10/27/2025	8:45:00 PM	0.06
10/27/2025	9:00:00 PM	0.06
10/27/2025	9:15:00 PM	0.06
10/27/2025	9:30:00 PM	0.07
10/27/2025	9:45:00 PM	0.07
10/27/2025	10:00:00 PM	0.07
10/27/2025	10:15:00 PM	0.07
10/27/2025	10:30:00 PM	0.08
10/27/2025	10:45:00 PM	0.08
10/27/2025	11:00:00 PM	0.08
10/27/2025	11:15:00 PM	0.08
10/27/2025	11:30:00 PM	0.08
10/27/2025	11:45:00 PM	0.08
10/28/2025	12:00:00 AM	0.08
10/28/2025	12:15:00 AM	0.08
10/28/2025	12:30:00 AM	0.08
10/28/2025	12:45:00 AM	0.08
10/28/2025	1:00:00 AM	0.08
10/28/2025	1:15:00 AM	0.08
10/28/2025	1:30:00 AM	0.08
10/28/2025	1:45:00 AM	0.08
10/28/2025	2:00:00 AM	0.08
10/28/2025	2:15:00 AM	0.08
10/28/2025	2:30:00 AM	0.08
10/28/2025	2:45:00 AM	0.08
10/28/2025	3:00:00 AM	0.08
10/28/2025	3:15:00 AM	0.08
10/28/2025	3:30:00 AM	0.08
10/28/2025	3:45:00 AM	0.08
10/28/2025	4:00:00 AM	0.08
10/28/2025	4:15:00 AM	0.08
10/28/2025	4:30:00 AM	0.08
10/28/2025	4:45:00 AM	0.08
10/28/2025	5:00:00 AM	0.08
10/28/2025	5:15:00 AM	0.08
10/28/2025	5:30:00 AM	0.08
10/28/2025	5:45:00 AM	0.08
10/28/2025	6:00:00 AM	0.08
10/28/2025	6:15:00 AM	0.08
10/28/2025	6:30:00 AM	0.08
10/28/2025	6:45:00 AM	0.08
10/28/2025	7:00:00 AM	0.08
10/28/2025	7:15:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
10/28/2025	7:30:00 AM	0.08
10/28/2025	7:45:00 AM	0.08
10/28/2025	8:00:00 AM	0.08
10/28/2025	8:15:00 AM	0.08
10/28/2025	8:30:00 AM	0.08
10/28/2025	8:45:00 AM	0.08
10/28/2025	9:00:00 AM	0.08
10/28/2025	9:15:00 AM	0.08
10/28/2025	9:30:00 AM	0.08
10/28/2025	9:45:00 AM	0.08
10/28/2025	10:00:00 AM	0.08
10/28/2025	10:15:00 AM	0.08
10/28/2025	10:30:00 AM	0.08
10/28/2025	10:45:00 AM	0.08
10/28/2025	11:00:00 AM	0.08
10/28/2025	11:15:00 AM	0.08
10/28/2025	11:30:00 AM	0.08
10/28/2025	11:45:00 AM	0.08
10/28/2025	12:00:00 PM	0.08
10/28/2025	12:15:00 PM	0.08
10/28/2025	12:30:00 PM	0.08
10/28/2025	12:45:00 PM	0.08
10/28/2025	1:00:00 PM	0.08
10/28/2025	1:15:00 PM	0.08
10/28/2025	1:30:00 PM	0.08
10/28/2025	1:45:00 PM	0.08
10/28/2025	2:00:00 PM	0.08
10/28/2025	2:15:00 PM	0.08
10/28/2025	2:30:00 PM	0.08
10/28/2025	2:45:00 PM	0.08
10/28/2025	3:00:00 PM	0.08
10/28/2025	3:15:00 PM	0.08
10/28/2025	3:30:00 PM	0.08
10/28/2025	3:45:00 PM	0.08
10/28/2025	4:00:00 PM	0.08
10/28/2025	4:15:00 PM	0.08
10/28/2025	4:30:00 PM	0.08
10/28/2025	4:45:00 PM	0.08
10/28/2025	5:00:00 PM	0.08
10/28/2025	5:15:00 PM	0.08
10/28/2025	5:30:00 PM	0.08
10/28/2025	5:45:00 PM	0.08
10/28/2025	6:00:00 PM	0.08
10/28/2025	6:15:00 PM	0.08
10/28/2025	6:30:00 PM	0.08
10/28/2025	6:45:00 PM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
10/28/2025	7:00:00 PM	0.08
10/28/2025	7:15:00 PM	0.08
10/28/2025	7:30:00 PM	0.08
10/28/2025	7:45:00 PM	0.08
10/28/2025	8:00:00 PM	0.08
10/28/2025	8:15:00 PM	0.08
10/28/2025	8:30:00 PM	0.08
10/28/2025	8:45:00 PM	0.08
10/28/2025	9:00:00 PM	0.08
10/28/2025	9:15:00 PM	0.08
10/28/2025	9:30:00 PM	0.08
10/28/2025	9:45:00 PM	0.08
10/28/2025	10:00:00 PM	0.08
10/28/2025	10:15:00 PM	0.08
10/28/2025	10:30:00 PM	0.08
10/28/2025	10:45:00 PM	0.08
10/28/2025	11:00:00 PM	0.08
10/28/2025	11:15:00 PM	0.08
10/28/2025	11:30:00 PM	0.08
10/28/2025	11:45:00 PM	0.08
10/29/2025	12:00:00 AM	0.08
10/29/2025	12:15:00 AM	0.08
10/29/2025	12:30:00 AM	0.08
10/29/2025	12:45:00 AM	0.08
10/29/2025	1:00:00 AM	0.08
10/29/2025	1:15:00 AM	0.08
10/29/2025	1:30:00 AM	0.08
10/29/2025	1:45:00 AM	0.08
10/29/2025	2:00:00 AM	0.08
10/29/2025	2:15:00 AM	0.08
10/29/2025	2:30:00 AM	0.08
10/29/2025	2:45:00 AM	0.08
10/29/2025	3:00:00 AM	0.08
10/29/2025	3:15:00 AM	0.08
10/29/2025	3:30:00 AM	0.08
10/29/2025	3:45:00 AM	0.08
10/29/2025	4:00:00 AM	0.08
10/29/2025	4:15:00 AM	0.08
10/29/2025	4:30:00 AM	0.08
10/29/2025	4:45:00 AM	0.08
10/29/2025	5:00:00 AM	0.08
10/29/2025	5:15:00 AM	0.08
10/29/2025	5:30:00 AM	0.08
10/29/2025	5:45:00 AM	0.08
10/29/2025	6:00:00 AM	0.08
10/29/2025	6:15:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
10/29/2025	6:30:00 AM	0.08
10/29/2025	6:45:00 AM	0.08
10/29/2025	7:00:00 AM	0.08
10/29/2025	7:15:00 AM	0.08
10/29/2025	7:30:00 AM	0.08
10/29/2025	7:45:00 AM	0.08
10/29/2025	8:00:00 AM	0.08
10/29/2025	8:15:00 AM	0.08
10/29/2025	8:30:00 AM	0.08
10/29/2025	8:45:00 AM	0.08
10/29/2025	9:00:00 AM	0.08
10/29/2025	9:15:00 AM	0.08
10/29/2025	9:30:00 AM	0.08
10/29/2025	9:45:00 AM	0.08
10/29/2025	10:00:00 AM	0.07
10/29/2025	10:15:00 AM	0.07
10/29/2025	10:30:00 AM	0.07
10/29/2025	10:45:00 AM	0.07
10/29/2025	11:00:00 AM	0.07
10/29/2025	11:15:00 AM	0.07
10/29/2025	11:30:00 AM	0.07
10/29/2025	11:45:00 AM	0.07
10/29/2025	12:00:00 PM	0.07
10/29/2025	12:15:00 PM	0.07
10/29/2025	12:30:00 PM	0.07
10/29/2025	12:45:00 PM	0.07
10/29/2025	1:00:00 PM	0.07
10/29/2025	1:15:00 PM	0.07
10/29/2025	1:30:00 PM	0.07
10/29/2025	1:45:00 PM	0.07
10/29/2025	2:00:00 PM	0.07
10/29/2025	2:15:00 PM	0.07
10/29/2025	2:30:00 PM	0.07
10/29/2025	2:45:00 PM	0.07
10/29/2025	3:00:00 PM	0.07
10/29/2025	3:15:00 PM	0.07
10/29/2025	3:30:00 PM	0.07
10/29/2025	3:45:00 PM	0.07
10/29/2025	4:00:00 PM	0.07
10/29/2025	4:15:00 PM	0.07
10/29/2025	4:30:00 PM	0.07
10/29/2025	4:45:00 PM	0.07
10/29/2025	5:00:00 PM	0.07
10/29/2025	5:15:00 PM	0.07
10/29/2025	5:30:00 PM	0.07
10/29/2025	5:45:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
10/29/2025	6:00:00 PM	0.07
10/29/2025	6:15:00 PM	0.07
10/29/2025	6:30:00 PM	0.06
10/29/2025	6:45:00 PM	0.06
10/29/2025	7:00:00 PM	0.06
10/29/2025	7:15:00 PM	0.06
10/29/2025	7:30:00 PM	0.06
10/29/2025	7:45:00 PM	0.06
10/29/2025	8:00:00 PM	0.06
10/29/2025	8:15:00 PM	0.06
10/29/2025	8:30:00 PM	0.06
10/29/2025	8:45:00 PM	0.06
10/29/2025	9:00:00 PM	0.06
10/29/2025	9:15:00 PM	0.06
10/29/2025	9:30:00 PM	0.06
10/29/2025	9:45:00 PM	0.07
10/29/2025	10:00:00 PM	0.07
10/29/2025	10:15:00 PM	0.07
10/29/2025	10:30:00 PM	0.07
10/29/2025	10:45:00 PM	0.07
10/29/2025	11:00:00 PM	0.07
10/29/2025	11:15:00 PM	0.07
10/29/2025	11:30:00 PM	0.07
10/29/2025	11:45:00 PM	0.07
10/30/2025	12:00:00 AM	0.07
10/30/2025	12:15:00 AM	0.07
10/30/2025	12:30:00 AM	0.07
10/30/2025	12:45:00 AM	0.07
10/30/2025	1:00:00 AM	0.07
10/30/2025	1:15:00 AM	0.07
10/30/2025	1:30:00 AM	0.07
10/30/2025	1:45:00 AM	0.07
10/30/2025	2:00:00 AM	0.07
10/30/2025	2:15:00 AM	0.07
10/30/2025	2:30:00 AM	0.07
10/30/2025	2:45:00 AM	0.07
10/30/2025	3:00:00 AM	0.07
10/30/2025	3:15:00 AM	0.07
10/30/2025	3:30:00 AM	0.07
10/30/2025	3:45:00 AM	0.07
10/30/2025	4:00:00 AM	0.07
10/30/2025	4:15:00 AM	0.07
10/30/2025	4:30:00 AM	0.07
10/30/2025	4:45:00 AM	0.07
10/30/2025	5:00:00 AM	0.07
10/30/2025	5:15:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
10/30/2025	5:30:00 AM	0.07
10/30/2025	5:45:00 AM	0.07
10/30/2025	6:00:00 AM	0.07
10/30/2025	6:15:00 AM	0.07
10/30/2025	6:30:00 AM	0.07
10/30/2025	6:45:00 AM	0.07
10/30/2025	7:00:00 AM	0.07
10/30/2025	7:15:00 AM	0.07
10/30/2025	7:30:00 AM	0.07
10/30/2025	7:45:00 AM	0.07
10/30/2025	8:00:00 AM	0.07
10/30/2025	8:15:00 AM	0.07
10/30/2025	8:30:00 AM	0.07
10/30/2025	8:45:00 AM	0.07
10/30/2025	9:00:00 AM	0.07
10/30/2025	9:15:00 AM	0.07
10/30/2025	9:30:00 AM	0.07
10/30/2025	9:45:00 AM	0.06
10/30/2025	10:00:00 AM	0.06
10/30/2025	10:15:00 AM	0.06
10/30/2025	10:30:00 AM	0.06
10/30/2025	10:45:00 AM	0.06
10/30/2025	11:00:00 AM	0.06
10/30/2025	11:15:00 AM	0.06
10/30/2025	11:30:00 AM	0.06
10/30/2025	11:45:00 AM	0.06
10/30/2025	12:00:00 PM	0.06
10/30/2025	12:15:00 PM	0.06
10/30/2025	12:30:00 PM	0.06
10/30/2025	12:45:00 PM	0.06
10/30/2025	1:00:00 PM	0.06
10/30/2025	1:15:00 PM	0.06
10/30/2025	1:30:00 PM	0.06
10/30/2025	1:45:00 PM	0.06
10/30/2025	2:00:00 PM	0.06
10/30/2025	2:15:00 PM	0.06
10/30/2025	2:30:00 PM	0.06
10/30/2025	2:45:00 PM	0.06
10/30/2025	3:00:00 PM	0.06
10/30/2025	3:15:00 PM	0.06
10/30/2025	3:30:00 PM	0.06
10/30/2025	3:45:00 PM	0.06
10/30/2025	4:00:00 PM	0.06
10/30/2025	4:15:00 PM	0.06
10/30/2025	4:30:00 PM	0.06
10/30/2025	4:45:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/30/2025	5:00:00 PM	0.06
10/30/2025	5:15:00 PM	0.06
10/30/2025	5:30:00 PM	0.06
10/30/2025	5:45:00 PM	0.06
10/30/2025	6:00:00 PM	0.06
10/30/2025	6:15:00 PM	0.06
10/30/2025	6:30:00 PM	0.06
10/30/2025	6:45:00 PM	0.06
10/30/2025	7:00:00 PM	0.06
10/30/2025	7:15:00 PM	0.06
10/30/2025	7:30:00 PM	0.06
10/30/2025	7:45:00 PM	0.06
10/30/2025	8:00:00 PM	0.06
10/30/2025	8:15:00 PM	0.06
10/30/2025	8:30:00 PM	0.06
10/30/2025	8:45:00 PM	0.06
10/30/2025	9:00:00 PM	0.06
10/30/2025	9:15:00 PM	0.06
10/30/2025	9:30:00 PM	0.06
10/30/2025	9:45:00 PM	0.06
10/30/2025	10:00:00 PM	0.06
10/30/2025	10:15:00 PM	0.06
10/30/2025	10:30:00 PM	0.06
10/30/2025	10:45:00 PM	0.06
10/30/2025	11:00:00 PM	0.06
10/30/2025	11:15:00 PM	0.07
10/30/2025	11:30:00 PM	0.07
10/30/2025	11:45:00 PM	0.07
10/31/2025	12:00:00 AM	0.07
10/31/2025	12:15:00 AM	0.07
10/31/2025	12:30:00 AM	0.07
10/31/2025	12:45:00 AM	0.07
10/31/2025	1:00:00 AM	0.07
10/31/2025	1:15:00 AM	0.07
10/31/2025	1:30:00 AM	0.07
10/31/2025	1:45:00 AM	0.07
10/31/2025	2:00:00 AM	0.07
10/31/2025	2:15:00 AM	0.07
10/31/2025	2:30:00 AM	0.07
10/31/2025	2:45:00 AM	0.07
10/31/2025	3:00:00 AM	0.07
10/31/2025	3:15:00 AM	0.07
10/31/2025	3:30:00 AM	0.07
10/31/2025	3:45:00 AM	0.07
10/31/2025	4:00:00 AM	0.07
10/31/2025	4:15:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
10/31/2025	4:30:00 AM	0.07
10/31/2025	4:45:00 AM	0.07
10/31/2025	5:00:00 AM	0.07
10/31/2025	5:15:00 AM	0.07
10/31/2025	5:30:00 AM	0.07
10/31/2025	5:45:00 AM	0.07
10/31/2025	6:00:00 AM	0.07
10/31/2025	6:15:00 AM	0.07
10/31/2025	6:30:00 AM	0.07
10/31/2025	6:45:00 AM	0.07
10/31/2025	7:00:00 AM	0.07
10/31/2025	7:15:00 AM	0.07
10/31/2025	7:30:00 AM	0.07
10/31/2025	7:45:00 AM	0.07
10/31/2025	8:00:00 AM	0.07
10/31/2025	8:15:00 AM	0.07
10/31/2025	8:30:00 AM	0.07
10/31/2025	8:45:00 AM	0.07
10/31/2025	9:00:00 AM	0.07
10/31/2025	9:15:00 AM	0.07
10/31/2025	9:30:00 AM	0.07
10/31/2025	9:45:00 AM	0.07
10/31/2025	10:00:00 AM	0.07
10/31/2025	10:15:00 AM	0.07
10/31/2025	10:30:00 AM	0.07
10/31/2025	10:45:00 AM	0.07
10/31/2025	11:00:00 AM	0.07
10/31/2025	11:15:00 AM	0.07
10/31/2025	11:30:00 AM	0.07
10/31/2025	11:45:00 AM	0.07
10/31/2025	12:00:00 PM	0.07
10/31/2025	12:15:00 PM	0.07
10/31/2025	12:30:00 PM	0.06
10/31/2025	12:45:00 PM	0.06
10/31/2025	1:00:00 PM	0.06
10/31/2025	1:15:00 PM	0.06
10/31/2025	1:30:00 PM	0.06
10/31/2025	1:45:00 PM	0.06
10/31/2025	2:00:00 PM	0.06
10/31/2025	2:15:00 PM	0.06
10/31/2025	2:30:00 PM	0.06
10/31/2025	2:45:00 PM	0.06
10/31/2025	3:00:00 PM	0.06
10/31/2025	3:15:00 PM	0.06
10/31/2025	3:30:00 PM	0.06
10/31/2025	3:45:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
10/31/2025	4:00:00 PM	0.06
10/31/2025	4:15:00 PM	0.06
10/31/2025	4:30:00 PM	0.06
10/31/2025	4:45:00 PM	0.06
10/31/2025	5:00:00 PM	0.06
10/31/2025	5:15:00 PM	0.06
10/31/2025	5:30:00 PM	0.06
10/31/2025	5:45:00 PM	0.06
10/31/2025	6:00:00 PM	0.06
10/31/2025	6:15:00 PM	0.06
10/31/2025	6:30:00 PM	0.06
10/31/2025	6:45:00 PM	0.06
10/31/2025	7:00:00 PM	0.06
10/31/2025	7:15:00 PM	0.06
10/31/2025	7:30:00 PM	0.06
10/31/2025	7:45:00 PM	0.06
10/31/2025	8:00:00 PM	0.06
10/31/2025	8:15:00 PM	0.06
10/31/2025	8:30:00 PM	0.06
10/31/2025	8:45:00 PM	0.06
10/31/2025	9:00:00 PM	0.06
10/31/2025	9:15:00 PM	0.06
10/31/2025	9:30:00 PM	0.06
10/31/2025	9:45:00 PM	0.06
10/31/2025	10:00:00 PM	0.06
10/31/2025	10:15:00 PM	0.06
10/31/2025	10:30:00 PM	0.06
10/31/2025	10:45:00 PM	0.06
10/31/2025	11:00:00 PM	0.06
10/31/2025	11:15:00 PM	0.06
10/31/2025	11:30:00 PM	0.06
10/31/2025	11:45:00 PM	0.06

Party: BLP BRP	Width: 21.1 ft	Processed by: BJA
Boat/Motor: BOAT	Area: 79.5 ft ²	Mean Velocity: 0.698 ft/s
Gage Height: 3.65 ft	G.H.Change: 0.000 ft	Discharge: 55.5 ft ³ /s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.00°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft ²	Diff.: 0.000%
Depth: Composite (BT)	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:		ADCP:	
BT 3-Beam Solution: YES	Max. Vel.: 2.65 ft/s	Type/Freq.: StreamPro / 2000 kHz	
WT 3-Beam Solution: YES	Max. Depth: 3.88 ft	Serial #: 2370	Firmware: 31.17
BT Error Vel.: 0.33 ft/s	Mean Depth: 3.77 ft	Bin Size: 4 cm	Blank: 3 cm
WT Error Vel.: 1.41 ft/s	% Meas.: 63.34	BT Mode: 10	BT Pings: 2
BT Up Vel.: 1.00 ft/s	Water Temp.: None	WT Mode: 12	WT Pings: 6
WT Up Vel.: 1.64 ft/s	ADCP Temp.: 59.1 °F		
Use Weighted Mean Depth: YES			

Performed Diag. Test: NO
 Performed Moving Bed Test: NO
 Performed Compass Calibration: NO Evaluation: NO
 Meas. Location: BRIDGE

Project Name: 251028 RINK_0.mmt
 Software: 2.26.00.04

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	L	2	2	35	6.07	32.4	4.31	5.05	3.85	51.7	21	78	08:39	08:39	0.46	0.66	0	0
001	R	2	2	33	6.67	35.7	5.09	5.51	3.96	56.9	21	80	08:40	08:40	0.48	0.71	0	0
002	L	2	2	32	6.92	36.9	5.26	4.73	4.24	58.0	21	79	08:40	08:41	0.49	0.73	0	1
003	R	2	2	36	6.22	33.2	5.12	4.41	3.67	52.7	21	81	08:41	08:42	0.44	0.65	0	1
004	L	2	2	35	7.06	37.6	5.23	4.59	3.78	58.3	21	79	08:42	08:42	0.46	0.73	0	1
Mean		2	2	34	6.59	35.2	5.00	4.86	3.90	55.5	21	80	Total	00:04	0.47	0.70	0	1
SDev		0	0	2	0.432	2.27	0.394	0.432	0.216	3.13	0.2	1.0			0.02	0.04		
SD/M		0.0%	0.0%	4.9%	6.6%	6.5%	7.9%	8.9%	5.5%	5.6%	0.7%	1.3%			3.8%	5.7%		

Remarks:

Discharge for transects in *italics* have a total Q more than 5% from the mean

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	1	0	0	30	29.1	-2.3	1.173	0.4	0.3	0	47.3	39.6	0	143	123	0	33	31	33
2025	10	1	0	10	30	29.7	-3.3	1.173	0.4	0.3	0	46.9	38.7	0	142	122	0	33	32	33
2025	10	1	0	20	30	29	-1.8	1.173	0.4	0.3	0	46.9	38.7	0	142	122	0	33	32	33
2025	10	1	0	30	30	29.3	-3.6	1.173	0.4	0.3	0	47.3	39.6	0	143	123	0	33	31	33
2025	10	1	0	40	30	28.1	-1.7	1.173	0.3	0.2	0	46.4	39.6	0	142	123	0	34	31	32
2025	10	1	0	50	30	28.8	-2.3	1.173	0.5	0.4	0	46.9	38.3	0	142	122	0	33	33	33
2025	10	1	1	0	30	29.1	-2.6	1.173	0.4	0.3	0	46.9	39.1	0	142	122	0	33	31	33
2025	10	1	1	10	30	29	-3.1	1.173	0.5	0.5	0	46.9	39.6	0	142	123	0	33	31	33
2025	10	1	1	20	30	28.8	-1.1	1.173	0.3	0.2	0	46.9	39.1	0	142	123	0	33	32	33
2025	10	1	1	30	30	30.2	-3.1	1.173	0.4	0.3	0	46.4	39.1	0	141	123	0	33	32	33
2025	10	1	1	40	30	30	-2.6	1.173	0.5	0.4	0	46.4	38.3	0	141	122	0	33	33	33
2025	10	1	1	50	30	28.9	-2.5	1.173	0.4	0.3	0	46.9	38.7	0	142	122	0	33	32	32
2025	10	1	2	0	30	28.8	-2.4	1.173	0.3	0.2	0	46	38.7	0	141	122	0	34	32	33
2025	10	1	2	10	30	29.1	-2.1	1.173	0.4	0.3	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	1	2	20	30	28.7	-3.5	1.173	0.4	0.3	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	1	2	30	30	28.8	-2.4	1.173	0.4	0.3	0	46.4	38.7	0	141	122	0	33	32	32
2025	10	1	2	40	30	28.7	-2.3	1.173	0.4	0.3	0	46.4	38.3	0	141	122	0	33	33	33
2025	10	1	2	50	30	28.4	-2.2	1.173	0.4	0.3	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	1	3	0	30	29.7	-3.8	1.173	0.4	0.3	0	46.4	39.1	0	141	122	0	33	31	33
2025	10	1	3	10	30	29	-2.1	1.173	0.4	0.3	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	1	3	20	30	28.9	-2	1.173	0.4	0.3	0	46	39.1	0	141	122	0	34	31	33
2025	10	1	3	30	30	30.5	-2.2	1.173	0.4	0.3	0	45.6	38.7	0	140	122	0	34	32	33
2025	10	1	3	40	30	29.7	-2	1.173	0.3	0.2	0	46	38.3	0	140	121	0	33	32	33
2025	10	1	3	50	30	29	-2.4	1.173	0.3	0.2	0	45.6	38.7	0	140	122	0	34	32	34
2025	10	1	4	0	30	28.1	-0.7	1.174	0.3	0.2	0	46	38.7	0	140	122	0	33	32	32
2025	10	1	4	10	30	28	-3.4	1.173	0.4	0.3	0	46	38.3	0	140	121	0	33	32	32
2025	10	1	4	20	30	29.8	-1.9	1.173	0.3	0.2	0	46	38.7	0	140	122	0	33	32	33
2025	10	1	4	30	30	28.6	-1.3	1.173	0.5	0.4	0	46	38.7	0	140	122	0	33	32	32
2025	10	1	4	40	30	30	-3.1	1.173	0.3	0.2	0	46.4	38.7	0	140	122	0	32	32	32
2025	10	1	4	50	30	28.3	-2.9	1.173	0.5	0.4	0	45.6	38.3	0	140	122	0	34	33	33
2025	10	1	5	0	30	29.5	-2.2	1.173	0.3	0.2	0	46	39.1	0	140	122	0	33	31	33
2025	10	1	5	10	30	28.4	-1.8	1.174	0.3	0.2	0	46	38.7	0	140	122	0	33	32	33
2025	10	1	5	20	30	28.9	-1.8	1.174	0.3	0.2	0	46	39.1	0	140	122	0	33	31	33
2025	10	1	5	30	30	29.6	-2.7	1.174	0.3	0.2	0	45.2	38.7	0	139	122	0	34	32	33
2025	10	1	5	40	30	29	-2.5	1.174	0.3	0.2	0	46	38.7	0	140	122	0	33	32	34
2025	10	1	5	50	30	28.7	-2.3	1.174	0.4	0.3	0	46	38.7	0	140	122	0	33	32	33
2025	10	1	6	0	30	28.6	-3.6	1.174	0.3	0.2	0	46	38.3	0	140	121	0	33	32	33
2025	10	1	6	10	30	29.6	-2.7	1.174	0.4	0.3	0	45.6	38.3	0	139	121	0	33	32	33
2025	10	1	6	20	30	28.6	-1.7	1.173	0.3	0.2	0	46	38.3	0	140	121	0	33	32	33
2025	10	1	6	30	30	28.5	-2.3	1.173	0.3	0.2	0	45.6	38.3	0	139	121	0	33	32	33
2025	10	1	6	40	30	28.3	-2.6	1.174	0.4	0.3	0	45.2	37.8	0	139	120	0	34	32	33
2025	10	1	6	50	30	28.4	-1.8	1.174	0.5	0.4	0	45.2	38.3	0	139	121	0	34	32	33
2025	10	1	7	0	30	29.3	-3.7	1.174	0.5	0.4	0	45.2	37.4	0	138	119	0	33	32	33
2025	10	1	7	10	30	29.3	-2.7	1.174	0.5	0.4	0	44.7	37.4	0	137	119	0	33	32	33
2025	10	1	7	20	30	29.1	-2.7	1.174	0.5	0.5	0	44.3	37	0	136	118	0	33	32	32
2025	10	1	7	30	30	29.5	-2.5	1.174	0.4	0.3	0	44.3	37	0	136	118	0	33	32	33
2025	10	1	7	40	30	28.9	-3.2	1.174	0.4	0.3	0	44.3	37	0	136	118	0	33	32	33
2025	10	1	7	50	30	29.2	-1.7	1.174	0.3	0.2	0	44.3	37.4	0	136	118	0	33	31	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	1	8	0	30	29.1	-2.9	1.174	0.3	0.2	0	44.3	37	0	136	118	0	33	32	32
2025	10	1	8	10	30	28.1	-1.9	1.174	0.3	0.2	0	43.9	37	0	135	118	0	33	32	32
2025	10	1	8	20	30	29.1	-1.9	1.174	0.3	0.2	0	43.9	36.5	0	135	117	0	33	32	33
2025	10	1	8	30	30	28.1	-1.5	1.174	0.5	0.4	0	43.9	36.5	0	135	117	0	33	32	34
2025	10	1	8	40	30	29.5	-1.8	1.174	0.3	0.2	0	43.4	36.1	0	134	116	0	33	32	33
2025	10	1	8	50	30	28.1	-2.8	1.174	0.5	0.4	0	43	36.1	0	133	116	0	33	32	33
2025	10	1	9	0	30	29.3	-2.7	1.174	0.5	0.4	0	43	35.7	0	133	115	0	33	32	32
2025	10	1	9	10	30	29.4	-2.3	1.174	0.3	0.2	0	43	35.7	0	133	115	0	33	32	32
2025	10	1	9	20	30	29.4	-1.9	1.174	0.5	0.4	0	43.4	35.7	0	133	115	0	32	32	32
2025	10	1	9	30	30	29.5	-1.3	1.174	0.3	0.2	0	43	35.7	0	133	115	0	33	32	33
2025	10	1	9	40	30	28.8	-1.9	1.174	0.3	0.2	0	43.4	35.7	0	133	115	0	32	32	33
2025	10	1	9	50	30	29.5	-2.2	1.174	0.4	0.3	0	42.6	35.7	0	133	116	0	34	33	32
2025	10	1	10	0	30	28.4	-1.7	1.174	0.3	0.2	0	43.4	36.5	0	133	116	0	32	31	33
2025	10	1	10	10	30	28.4	-2.5	1.174	0.3	0.2	0	43.4	36.1	0	134	116	0	33	32	33
2025	10	1	10	20	30	28.8	-2.1	1.174	0.4	0.3	0	43.4	36.5	0	134	117	0	33	32	33
2025	10	1	10	30	30	29.2	-2.7	1.175	0.3	0.2	0	43.4	35.7	0	134	116	0	33	33	32
2025	10	1	10	40	30	28.7	-3.5	1.175	0.3	0.2	0	43	36.1	0	133	116	0	33	32	33
2025	10	1	10	50	30	28.4	-3.1	1.175	0.4	0.3	0	43	36.1	0	133	116	0	33	32	33
2025	10	1	11	0	30	28	-3.2	1.175	0.4	0.3	0	43	36.1	0	133	116	0	33	32	32
2025	10	1	11	10	30	29.5	-3.2	1.175	0.4	0.3	0	43	36.1	0	133	116	0	33	32	33
2025	10	1	11	20	30	28.2	-2.9	1.174	0.4	0.3	0	42.6	36.1	0	133	116	0	34	32	33
2025	10	1	11	30	30	28.9	-2.3	1.174	0.3	0.2	0	43	36.1	0	134	117	0	34	33	33
2025	10	1	11	40	30	30.4	-3.1	1.174	0.4	0.3	0	43	36.5	0	133	116	0	33	31	33
2025	10	1	11	50	30	28.7	-2.3	1.174	0.4	0.3	0	43	36.1	0	134	117	0	34	33	32
2025	10	1	12	0	30	29.1	-3.5	1.175	0.4	0.3	0	43	36.1	0	133	116	0	33	32	33
2025	10	1	12	10	30	29.1	-2.7	1.174	0.3	0.2	0	42.6	35.7	0	133	116	0	34	33	33
2025	10	1	12	20	30	28.2	-3.1	1.174	0.4	0.3	0	43.4	36.1	0	134	117	0	33	33	33
2025	10	1	12	30	30	28.7	-2.4	1.174	0.3	0.2	0	43	36.1	0	133	116	0	33	32	33
2025	10	1	12	40	30	29.8	-2.7	1.174	0.3	0.2	0	43	36.5	0	134	117	0	34	32	32
2025	10	1	12	50	30	27.8	-2.2	1.174	0.4	0.3	0	43	36.1	0	133	116	0	33	32	32
2025	10	1	13	0	30	29.7	-3.1	1.174	0.4	0.3	0	43.4	36.5	0	134	117	0	33	32	33
2025	10	1	13	10	30	28.4	-2.5	1.174	0.3	0.2	0	43.9	36.1	0	134	117	0	32	33	32
2025	10	1	13	20	30	28.7	-2.3	1.173	0.3	0.2	0	43.9	36.5	0	135	117	0	33	32	32
2025	10	1	13	30	30	29	-2.4	1.173	0.3	0.2	0	43.4	35.7	0	134	116	0	33	33	32
2025	10	1	13	40	30	29.2	-3.1	1.173	0.4	0.3	0	43.4	36.1	0	134	116	0	33	32	34
2025	10	1	13	50	30	28.1	-2.5	1.172	0.3	0.2	0	43.9	35.7	0	135	116	0	33	33	33
2025	10	1	14	0	30	28.9	-2.8	1.173	0.4	0.3	0	44.3	37	0	135	117	0	32	31	32
2025	10	1	14	10	30	28.1	-2.5	1.172	0.3	0.2	0	43.9	36.1	0	135	116	0	33	32	32
2025	10	1	14	20	30	28.2	-3	1.173	0.3	0.2	0	43.9	36.5	0	135	117	0	33	32	33
2025	10	1	14	30	30	28.2	-2.4	1.171	0.3	0.2	0	43	36.1	0	134	116	0	34	32	33
2025	10	1	14	40	30	28.6	-2.9	1.171	0.3	0.2	0	43.9	36.5	0	135	117	0	33	32	33
2025	10	1	14	50	30	28.7	-3.2	1.171	0.3	0.2	0	43.9	36.1	0	135	116	0	33	32	33
2025	10	1	15	0	30	28.6	-2.9	1.172	0.4	0.3	0	43.9	37	0	136	117	0	34	31	33
2025	10	1	15	10	30	28.9	-1.3	1.171	0.4	0.3	0	44.7	37	0	137	118	0	33	32	33
2025	10	1	15	20	30	29.2	-3	1.171	0.4	0.3	0	44.3	37	0	136	118	0	33	32	33
2025	10	1	15	30	30	28.4	-2.2	1.171	0.3	0.2	0	44.3	37	0	136	118	0	33	32	33
2025	10	1	15	40	30	29.1	-2.4	1.17	0.3	0.2	0	44.3	37	0	136	118	0	33	32	33
2025	10	1	15	50	30	28.7	-2.2	1.171	0.4	0.3	0	43.9	37	0	136	118	0	34	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	1	16	0	30	28.8	-2.4	1.171	0.6	0.5	0	44.3	37	0	136	118	0	33	32	32
2025	10	1	16	10	30	27.8	-1.4	1.17	0.4	0.3	0	44.7	37.4	0	137	118	0	33	31	33
2025	10	1	16	20	30	28.8	-2.7	1.17	0.5	0.4	0	44.3	37	0	136	118	0	33	32	33
2025	10	1	16	30	30	28.1	-2.4	1.17	0.4	0.3	0	44.3	36.5	0	136	117	0	33	32	33
2025	10	1	16	40	30	28.8	-1.9	1.17	0.3	0.2	0	43.9	37	0	135	117	0	33	31	32
2025	10	1	16	50	30	29.7	-2.7	1.171	0.3	0.2	0	43.9	36.5	0	135	117	0	33	32	33
2025	10	1	17	0	30	28.5	-2.7	1.169	0.3	0.2	0	43.9	36.5	0	135	117	0	33	32	32
2025	10	1	17	10	30	27.7	-3	1.17	0.3	0.2	0	44.3	36.5	0	136	117	0	33	32	33
2025	10	1	17	20	30	29	-1.9	1.17	0.3	0.2	0	43.9	36.5	0	136	117	0	34	32	33
2025	10	1	17	30	30	28.1	-2	1.169	0.3	0.2	0	44.7	36.5	0	137	117	0	33	32	32
2025	10	1	17	40	30	28.4	-2	1.17	0.3	0.2	0	45.2	37	0	138	118	0	33	32	32
2025	10	1	17	50	30	29.2	-3	1.169	0.3	0.2	0	44.7	36.5	0	137	118	0	33	33	33
2025	10	1	18	0	30	28.1	-2.6	1.17	0.4	0.3	0	44.3	36.5	0	136	117	0	33	32	32
2025	10	1	18	10	30	29.5	-1.8	1.17	0.5	0.5	0	44.7	37.4	0	137	118	0	33	31	33
2025	10	1	18	20	30	29.6	-2.7	1.169	0.3	0.2	0	44.3	36.5	0	136	117	0	33	32	33
2025	10	1	18	30	30	28	-3.1	1.17	0.3	0.2	0	44.3	37	0	137	118	0	34	32	32
2025	10	1	18	40	30	29.3	-2.4	1.171	0.3	0.2	0	44.7	37	0	137	118	0	33	32	33
2025	10	1	18	50	30	28.8	-2.9	1.171	0.3	0.2	0	45.2	37.4	0	138	119	0	33	32	33
2025	10	1	19	0	30	28.5	-1.9	1.17	0.3	0.2	0	45.2	37.4	0	138	119	0	33	32	33
2025	10	1	19	10	30	29.1	-1.9	1.171	0.3	0.2	0	45.6	38.3	0	139	120	0	33	31	33
2025	10	1	19	20	30	28.6	-2.7	1.17	0.4	0.3	0	46	37.8	0	140	120	0	33	32	33
2025	10	1	19	30	30	28.7	-2.7	1.171	0.3	0.2	0	46	38.3	0	140	121	0	33	32	33
2025	10	1	19	40	30	29.5	-2	1.171	0.3	0.2	0	46	38.3	0	140	121	0	33	32	33
2025	10	1	19	50	30	28.5	-2.1	1.171	0.3	0.2	0	46.4	38.3	0	141	122	0	33	33	32
2025	10	1	20	0	30	28.9	-2.6	1.172	0.4	0.3	0	46	38.7	0	141	122	0	34	32	33
2025	10	1	20	10	30	28.5	-2.2	1.172	0.4	0.3	0	46	38.3	0	140	121	0	33	32	33
2025	10	1	20	20	30	30.4	-2.7	1.172	0.4	0.3	0	46.4	38.3	0	141	121	0	33	32	33
2025	10	1	20	30	30	28.9	-2.4	1.172	0.4	0.3	0	46	38.7	0	141	122	0	34	32	33
2025	10	1	20	40	30	29.4	-3.1	1.172	0.3	0.2	0	45.6	38.7	0	140	121	0	34	31	32
2025	10	1	20	50	30	29.2	-4	1.172	0.3	0.2	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	1	21	0	30	30.7	-2.7	1.172	0.5	0.4	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	1	21	10	30	30.1	-2.4	1.172	0.5	0.4	0	46	38.7	0	141	122	0	34	32	33
2025	10	1	21	20	30	29.7	-1.4	1.172	0.3	0.2	0	46.4	38.7	0	141	122	0	33	32	32
2025	10	1	21	30	30	28.1	-2.7	1.172	0.4	0.3	0	46.4	39.1	0	142	123	0	34	32	33
2025	10	1	21	40	30	28.9	-2.7	1.172	0.3	0.2	0	46.4	38.3	0	141	122	0	33	33	33
2025	10	1	21	50	30	28.6	-2.4	1.172	0.3	0.2	0	46.9	38.7	0	142	122	0	33	32	33
2025	10	1	22	0	30	29.5	-2.6	1.172	0.4	0.3	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	1	22	10	30	29.6	-2.7	1.172	0.4	0.3	0	46	38.7	0	141	122	0	34	32	33
2025	10	1	22	20	30	29.1	-2.9	1.172	0.4	0.3	0	46.4	38.7	0	141	122	0	33	32	32
2025	10	1	22	30	30	28.4	-1.5	1.172	0.4	0.3	0	46.4	38.7	0	142	122	0	34	32	33
2025	10	1	22	40	30	29.7	-2.8	1.172	0.4	0.3	0	46.9	38.3	0	141	122	0	32	33	33
2025	10	1	22	50	30	29	-2.7	1.172	0.4	0.3	0	46	38.7	0	141	122	0	34	32	34
2025	10	1	23	0	30	29.2	-2.8	1.172	0.4	0.3	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	1	23	10	30	28.5	-3	1.172	0.3	0.2	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	1	23	20	30	29.8	-1.9	1.172	0.3	0.2	0	46.4	38.7	0	141	122	0	33	32	32
2025	10	1	23	30	30	29.5	-2.8	1.173	0.4	0.3	0	46	38.7	0	141	122	0	34	32	33
2025	10	1	23	40	30	29.2	-2	1.172	0.3	0.2	0	46	38.7	0	141	122	0	34	32	33
2025	10	1	23	50	30	27.9	-1.7	1.172	0.4	0.3	0	46.4	38.7	0	141	122	0	33	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	2	0	0	30	27.9	-2.2	1.172	0.3	0.2	0	46.4	39.1	0	141	123	0	33	32	32
2025	10	2	0	10	30	29.9	-1.6	1.173	0.3	0.2	0	46	38.7	0	141	122	0	34	32	33
2025	10	2	0	20	30	29.1	-2.9	1.172	0.3	0.2	0	46.4	38.3	0	141	122	0	33	33	33
2025	10	2	0	30	30	30.2	-3.2	1.172	0.4	0.3	0	46	38.3	0	140	121	0	33	32	33
2025	10	2	0	40	30	30.5	-1.8	1.173	0.4	0.3	0	46.4	39.1	0	141	122	0	33	31	33
2025	10	2	0	50	30	28.7	-2.5	1.173	0.5	0.4	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	2	1	0	30	28.6	-2.4	1.173	0.3	0.2	0	46.4	39.1	0	141	123	0	33	32	33
2025	10	2	1	10	30	28.8	-2.9	1.173	0.3	0.2	0	46	38.7	0	141	122	0	34	32	33
2025	10	2	1	20	30	30.6	-3.4	1.173	0.4	0.3	0	46	38.3	0	140	121	0	33	32	33
2025	10	2	1	30	30	29.4	-3.1	1.173	0.3	0.2	0	46	38.3	0	140	121	0	33	32	33
2025	10	2	1	40	30	29.3	-2.6	1.173	0.3	0.2	0	45.6	38.7	0	140	122	0	34	32	33
2025	10	2	1	50	30	29.8	-3.6	1.173	0.5	0.4	0	46	38.7	0	140	122	0	33	32	33
2025	10	2	2	0	30	28.8	-3.5	1.173	0.3	0.2	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	2	2	10	30	28.4	-2.5	1.173	0.5	0.4	0	46	38.7	0	141	122	0	34	32	33
2025	10	2	2	20	30	29.8	-2	1.173	0.3	0.2	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	2	2	30	30	28.7	-3	1.173	0.4	0.3	0	46	38.7	0	140	122	0	33	32	33
2025	10	2	2	40	30	28.3	-2.6	1.173	0.4	0.3	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	2	2	50	30	29.3	-3.6	1.173	0.3	0.2	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	2	3	0	30	29.8	-3.1	1.173	0.5	0.4	0	46	38.7	0	140	122	0	33	32	32
2025	10	2	3	10	30	28.4	-3.4	1.173	0.4	0.3	0	46.4	38.3	0	141	122	0	33	33	32
2025	10	2	3	20	30	29.9	-2.9	1.173	0.5	0.5	0	46	38.7	0	140	122	0	33	32	33
2025	10	2	3	30	30	29.2	-2.7	1.173	0.4	0.3	0	46	38.3	0	140	122	0	33	33	33
2025	10	2	3	40	30	27.6	-1.9	1.173	0.3	0.2	0	46	38.7	0	140	122	0	33	32	33
2025	10	2	3	50	30	28.2	-2.7	1.173	0.3	0.2	0	45.6	38.7	0	140	122	0	34	32	33
2025	10	2	4	0	30	28.8	-2.6	1.173	0.4	0.3	0	45.6	38.7	0	139	122	0	33	32	33
2025	10	2	4	10	30	28.8	-2.6	1.173	0.3	0.2	0	46	38.7	0	140	122	0	33	32	33
2025	10	2	4	20	30	29	-2.2	1.173	0.4	0.3	0	45.6	38.7	0	140	122	0	34	32	34
2025	10	2	4	30	30	30.2	-2.2	1.174	0.4	0.3	0	45.6	38.7	0	140	122	0	34	32	33
2025	10	2	4	40	30	30.1	-2.1	1.174	0.3	0.2	0	45.2	38.3	0	139	121	0	34	32	32
2025	10	2	4	50	30	29.4	-3.1	1.174	0.4	0.3	0	46	38.7	0	140	122	0	33	32	33
2025	10	2	5	0	30	29.7	-2.2	1.174	0.4	0.3	0	45.6	38.7	0	139	122	0	33	32	33
2025	10	2	5	10	30	28	-2.7	1.174	0.3	0.2	0	46	38.3	0	140	122	0	33	33	33
2025	10	2	5	20	30	29.5	-2.2	1.174	0.5	0.4	0	46	38.7	0	140	122	0	33	32	33
2025	10	2	5	30	30	28.5	-2.8	1.174	0.3	0.2	0	45.6	38.7	0	140	122	0	34	32	32
2025	10	2	5	40	30	29.7	-3.1	1.174	0.3	0.2	0	46	38.7	0	140	122	0	33	32	33
2025	10	2	5	50	30	30	-2.6	1.174	0.4	0.3	0	45.2	38.7	0	139	122	0	34	32	33
2025	10	2	6	0	30	29.6	-2.7	1.174	0.4	0.3	0	46	38.7	0	140	122	0	33	32	33
2025	10	2	6	10	30	29.2	-2.3	1.174	0.4	0.3	0	45.6	38.3	0	139	121	0	33	32	32
2025	10	2	6	20	30	28.8	-2.7	1.174	0.4	0.3	0	45.6	38.7	0	140	122	0	34	32	33
2025	10	2	6	30	30	28.4	-2	1.174	0.5	0.4	0	45.6	38.3	0	139	121	0	33	32	33
2025	10	2	6	40	30	30.4	-2.1	1.174	0.4	0.3	0	45.6	38.3	0	139	121	0	33	32	33
2025	10	2	6	50	30	29.7	-3.5	1.174	0.5	0.4	0	45.6	37.8	0	139	120	0	33	32	33
2025	10	2	7	0	30	29.7	-3.1	1.174	0.4	0.3	0	45.2	37.8	0	138	120	0	33	32	32
2025	10	2	7	10	30	29.6	-2.9	1.174	0.3	0.2	0	44.7	37.8	0	137	120	0	33	32	33
2025	10	2	7	20	30	28	-2	1.174	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	2	7	30	30	29.1	-2.9	1.174	0.4	0.3	0	44.7	37.4	0	137	119	0	33	32	33
2025	10	2	7	40	30	29.4	-3.4	1.174	0.4	0.3	0	43.9	37.4	0	136	119	0	34	32	33
2025	10	2	7	50	30	31	-2.9	1.174	0.3	0.2	0	43.9	37.4	0	136	119	0	34	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	2	8	0	30	29.6	-2.1	1.174	0.3	0.2	0	44.3	37.4	0	136	119	0	33	32	32
2025	10	2	8	10	30	29.1	-2.2	1.174	0.4	0.3	0	43.9	37	0	135	118	0	33	32	32
2025	10	2	8	20	30	28.6	-2.6	1.175	0.3	0.2	0	43.9	37	0	135	118	0	33	32	33
2025	10	2	8	30	30	28.4	-2.7	1.175	0.4	0.3	0	43.4	37	0	135	118	0	34	32	33
2025	10	2	8	40	30	29.1	-2.6	1.175	0.3	0.2	0	43.4	36.5	0	135	118	0	34	33	33
2025	10	2	8	50	30	29.9	-3.2	1.175	0.3	0.2	0	43.4	37	0	135	118	0	34	32	33
2025	10	2	9	0	30	28.8	-1.8	1.175	0.5	0.4	0	43.4	37	0	135	118	0	34	32	33
2025	10	2	9	10	30	29.4	-2.1	1.175	0.3	0.2	0	43.4	36.5	0	135	117	0	34	32	32
2025	10	2	9	20	30	30.1	-2.7	1.175	0.3	0.2	0	43.4	36.5	0	134	117	0	33	32	33
2025	10	2	9	30	30	27.9	-1.9	1.175	0.4	0.3	0	43.4	36.5	0	135	117	0	34	32	34
2025	10	2	9	40	30	29.3	-2.7	1.175	0.3	0.2	0	44.3	37.4	0	136	119	0	33	32	34
2025	10	2	9	50	30	29.3	-3.5	1.175	0.3	0.2	0	43.4	37	0	135	118	0	34	32	33
2025	10	2	10	0	30	28.5	-2.3	1.175	0.4	0.3	0	43.9	37	0	135	118	0	33	32	33
2025	10	2	10	10	30	30.1	-3.2	1.175	0.5	0.4	0	43.9	37.4	0	135	118	0	33	31	33
2025	10	2	10	20	30	29.3	-3.3	1.175	0.3	0.2	0	44.3	37	0	136	119	0	33	33	33
2025	10	2	10	30	30	29.2	-3.1	1.175	0.3	0.2	0	44.3	37.4	0	136	119	0	33	32	33
2025	10	2	10	40	30	29	-2.2	1.176	0.4	0.3	0	44.3	37.4	0	136	120	0	33	33	33
2025	10	2	10	50	30	29	-2	1.175	0.3	0.2	0	43.9	37.8	0	136	120	0	34	32	33
2025	10	2	11	0	30	29.6	-2.2	1.176	0.3	0.2	0	44.3	37.8	0	136	120	0	33	32	33
2025	10	2	11	10	30	28.9	-2.7	1.176	0.4	0.3	0	43.9	37.8	0	135	119	0	33	31	33
2025	10	2	11	20	30	29.3	-3.7	1.176	0.3	0.2	0	43.4	37.4	0	135	119	0	34	32	33
2025	10	2	11	30	30	29.4	-3.2	1.176	0.5	0.4	0	43.4	36.5	0	134	117	0	33	32	33
2025	10	2	11	40	30	29.8	-2.3	1.176	0.3	0.2	0	43	36.5	0	134	117	0	34	32	33
2025	10	2	11	50	30	28.6	-3.2	1.176	0.3	0.2	0	43	37	0	134	117	0	34	31	33
2025	10	2	12	0	30	29.3	-4	1.176	0.3	0.2	0	43.9	36.5	0	134	117	0	32	32	33
2025	10	2	12	10	30	28.9	-3.1	1.176	0.3	0.2	0	43.9	36.5	0	135	118	0	33	33	32
2025	10	2	12	20	30	28.2	-2.7	1.176	0.4	0.3	0	43.4	36.5	0	134	117	0	33	32	33
2025	10	2	12	30	30	29.2	-2.8	1.176	0.4	0.3	0	43.4	36.5	0	134	117	0	33	32	33
2025	10	2	12	40	30	28.8	-2.7	1.176	0.3	0.2	0	43.4	37	0	134	117	0	33	31	33
2025	10	2	12	50	30	29.5	-3.3	1.176	0.3	0.2	0	43	36.1	0	134	116	0	34	32	32
2025	10	2	13	0	30	29	-2.2	1.176	0.5	0.4	0	43.4	36.5	0	134	117	0	33	32	33
2025	10	2	13	10	30	29.8	-1.9	1.176	0.5	0.4	0	43.4	36.1	0	134	117	0	33	33	32
2025	10	2	13	20	30	30	-2.3	1.177	0.5	0.4	0	43.4	36.5	0	134	117	0	33	32	33
2025	10	2	13	30	30	28.5	-2.7	1.176	0.4	0.3	0	43.4	36.5	0	134	117	0	33	32	33
2025	10	2	13	40	30	29.5	-2.8	1.176	0.4	0.3	0	43	36.5	0	134	117	0	34	32	33
2025	10	2	13	50	30	28.6	-2.1	1.177	0.5	0.4	0	43.9	37	0	135	118	0	33	32	33
2025	10	2	14	0	30	29.4	-3.1	1.176	0.3	0.2	0	43.4	37.4	0	134	118	0	33	31	33
2025	10	2	14	10	30	29	-3	1.177	0.3	0.2	0	43.9	37	0	135	118	0	33	32	32
2025	10	2	14	20	30	29.4	-1.8	1.177	0.4	0.3	0	43.9	37	0	135	118	0	33	32	33
2025	10	2	14	30	30	28.9	-3.4	1.177	0.4	0.3	0	43.4	37	0	135	118	0	34	32	33
2025	10	2	14	40	30	28.6	-2	1.177	0.3	0.2	0	43.4	37.4	0	135	119	0	34	32	33
2025	10	2	14	50	30	28.7	-2	1.177	0.4	0.3	0	43.9	37.4	0	136	119	0	34	32	32
2025	10	2	15	0	30	28.8	-2.6	1.176	0.3	0.2	0	44.3	37	0	136	119	0	33	33	33
2025	10	2	15	10	30	27.9	-2	1.176	0.4	0.3	0	44.7	38.3	0	137	121	0	33	32	33
2025	10	2	15	20	30	28.7	-3.1	1.175	0.3	0.2	0	45.2	38.3	0	138	121	0	33	32	32
2025	10	2	15	30	30	29.7	-2.5	1.176	0.4	0.3	0	45.6	39.1	0	139	123	0	33	32	33
2025	10	2	15	40	30	28.9	-3.4	1.175	0.4	0.3	0	46	39.1	0	140	123	0	33	32	33
2025	10	2	15	50	30	28.7	-2.5	1.176	0.3	0.2	0	46.4	39.6	0	141	124	0	33	32	32

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	10	2	16	0	30	29.1	-1.8	1.176	0.3	0.2	0	44.7	38.3	0	138	121	0	34	32	33	
2025	10	2	16	10	30	29.4	-2.2	1.176	0.3	0.2	0	45.2	38.3	0	138	121	0	33	32	32	
2025	10	2	16	20	30	28.9	-2.2	1.175	0.3	0.2	0	45.2	37.8	0	138	121	0	33	33	33	
2025	10	2	16	30	30	29.4	-2.9	1.176	0.3	0.2	0	44.7	38.3	0	138	121	0	34	32	33	
2025	10	2	16	40	30	29.9	-2.3	1.177	0.4	0.3	0	46	38.3	0	139	121	0	32	32	33	
2025	10	2	16	50	30	29.4	-2.7	1.176	0.4	0.3	0	45.2	38.3	0	139	121	0	34	32	33	
2025	10	2	17	0	30	27.5	-1.9	1.176	0.4	0.3	0	45.2	37.8	0	139	120	0	34	32	32	
2025	10	2	17	10	30	30.1	-3.1	1.176	0.4	0.3	0	45.2	37.8	0	138	120	0	33	32	33	
2025	10	2	17	20	30	28.5	-1.8	1.176	0.4	0.3	0	44.7	37.4	0	138	120	0	34	33	33	
2025	10	2	17	30	30	29.1	-0.8	1.176	0.5	0.4	0	44.7	37.4	0	137	119	0	33	32	33	
2025	10	2	17	40	30	29.3	-3.1	1.176	0.4	0.3	0	44.7	37.4	0	137	119	0	33	32	33	
2025	10	2	17	50	30	29.2	-3.5	1.177	0.3	0.2	0	44.7	37.8	0	137	120	0	33	32	33	
2025	10	2	18	0	30	29.1	-2.2	1.177	0.3	0.2	0	45.2	37.8	0	138	120	0	33	32	33	
2025	10	2	18	10	30	28.7	-2.5	1.176	0.3	0.2	0	45.2	37.8	0	138	120	0	33	32	32	
2025	10	2	18	20	30	29.2	-2.3	1.177	0.4	0.3	0	45.2	38.3	0	138	120	0	33	31	33	
2025	10	2	18	30	30	29.3	-2.5	1.177	0.3	0.2	0	45.6	37.8	0	139	120	0	33	32	33	
2025	10	2	18	40	30	28.6	-2.6	1.175	0.4	0.3	0	45.2	37.8	0	138	120	0	33	32	33	
2025	10	2	18	50	30	28.9	-0.9	1.178	0.4	0.3	0	45.6	37.8	0	140	121	0	34	33	33	
2025	10	2	19	0	30	28.4	-2.4	1.176	0.3	0.2	0	45.2	38.3	0	139	121	0	34	32	33	
2025	10	2	19	10	30	28	-2.8	1.178	0.4	0.3	0	45.6	38.7	0	139	122	0	33	32	33	
2025	10	2	19	20	30	29.2	-2.8	1.177	0.3	0.2	0	45.6	38.7	0	140	122	0	34	32	33	
2025	10	2	19	30	30	28.8	-2.7	1.177	0.3	0.2	0	46	38.3	0	140	122	0	33	33	33	
2025	10	2	19	40	30	30.3	-2.8	1.178	0.3	0.2	0	46	39.1	0	140	123	0	33	32	33	
2025	10	2	19	50	30	28.8	-3.2	1.177	0.4	0.3	0	46	39.1	0	141	123	0	34	32	33	
2025	10	2	20	0	30	28.8	-3.5	1.178	0.4	0.3	0	46.4	38.7	0	141	123	0	33	33	33	
2025	10	2	20	10	30	28.8	-2.7	1.177	0.5	0.4	0	46	39.1	0	140	123	0	33	32	33	
2025	10	2	20	20	30	30.4	-3.2	1.177	0.3	0.2	0	46.4	39.1	0	142	123	0	34	32	32	
2025	10	2	20	30	30	29.9	-2.1	1.179	0.3	0.2	0	46.4	39.1	0	141	123	0	33	32	33	
2025	10	2	20	40	30	28.6	-3.2	1.178	0.4	0.3	0	46	39.1	0	141	123	0	34	32	33	
2025	10	2	20	50	30	28.9	-1.8	1.178	0.3	0.2	0	46	39.1	0	141	123	0	34	32	34	
2025	10	2	21	0	30	30	-2.6	1.179	0.5	0.4	0	46.4	38.3	0	141	122	0	33	33	33	
2025	10	2	21	10	30	28.9	-1.1	1.177	0.3	0.2	0	46.4	39.1	0	141	123	0	33	32	33	
2025	10	2	21	20	30	30.5	-2.2	1.177	0.3	0.2	0	46	38.7	0	141	123	0	34	33	33	
2025	10	2	21	30	30	29.6	-2.6	1.178	0.3	0.2	0	46.4	38.7	0	142	123	0	34	33	33	
2025	10	2	21	40	30	28.5	-2.7	1.178	0.3	0.2	0	47.3	38.7	0	142	123	0	32	33	34	
2025	10	2	21	50	30	28.9	-1.8	1.178	0.4	0.3	0	46.9	39.1	0	142	123	0	33	32	34	
2025	10	2	22	0	30	29.4	-2.6	1.178	0.3	0.2	0	46.9	39.1	0	142	123	0	33	32	33	
2025	10	2	22	10	30	29.3	-2.1	1.179	0.3	0.2	0	46.9	39.1	0	142	123	0	33	32	33	
2025	10	2	22	20	30	27.2	-1.5	1.179	0.3	0.2	0	46.9	39.1	0	142	123	0	33	32	34	
2025	10	2	22	30	30	30	-2.5	1.178	0.4	0.3	0	46.9	39.1	0	142	123	0	33	32	32	
2025	10	2	22	40	30	28.7	-3	1.179	0.3	0.2	0	44.7	39.1	0	137	123	0	33	32	33	
2025	10	2	22	50	30	29	-2.3	1.18	0.4	0.3	0	46.4	39.1	0	142	123	0	34	32	33	
2025	10	2	23	0	30	27.2	-2.8	1.179	0.3	0.2	0	46.4	39.1	0	142	123	0	34	32	33	
2025	10	2	23	10	30	30.4	-2.6	1.179	0.3	0.2	0	47.3	39.1	0	143	123	0	33	32	33	
2025	10	2	23	20	30	28.7	-2.5	1.18	0.3	0.2	0	46	39.1	0	141	122	0	34	31	33	
2025	10	2	23	30	30	29.8	-2	1.18	0.3	0.2	0	46.4	38.3	0	141	122	0	33	33	33	
2025	10	2	23	40	30	28.8	-1.9	1.179	0.5	0.5	0	46.4	39.1	0	141	123	0	33	32	33	
2025	10	2	23	50	30	29.1	-2.9	1.18	0.5	0.5	0	46	38.7	0	141	122	0	34	32	33	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	3	0	0	30	28.6	-2.3	1.18	0.4	0.3	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	3	0	10	30	28.7	-2.3	1.18	0.4	0.3	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	3	0	20	30	28.8	-2.5	1.181	0.3	0.2	0	46.4	39.1	0	141	123	0	33	32	33
2025	10	3	0	30	30	29.9	-2.9	1.181	0.4	0.3	0	46.9	39.1	0	141	123	0	32	32	33
2025	10	3	0	40	30	29.4	-2.6	1.181	0.3	0.2	0	46.4	39.1	0	141	123	0	33	32	33
2025	10	3	0	50	30	28.8	-3.6	1.18	0.3	0.2	0	46	38.7	0	141	123	0	34	33	33
2025	10	3	1	0	30	29.2	-3	1.18	0.3	0.2	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	3	1	10	30	28	-3.1	1.181	0.3	0.2	0	46.4	39.1	0	141	123	0	33	32	33
2025	10	3	1	20	30	29.7	-2.6	1.181	0.3	0.2	0	46	39.1	0	141	123	0	34	32	33
2025	10	3	1	30	30	28.7	-2.8	1.182	0.5	0.4	0	46.4	39.6	0	141	123	0	33	31	33
2025	10	3	1	40	30	29.1	-2.2	1.181	0.4	0.3	0	46.9	39.1	0	142	123	0	33	32	33
2025	10	3	1	50	30	29	-1.7	1.18	0.3	0.2	0	46.4	38.7	0	142	123	0	34	33	33
2025	10	3	2	0	30	29.2	-2.3	1.181	0.3	0.2	0	45.6	39.1	0	140	123	0	34	32	34
2025	10	3	2	10	30	29.4	-3.4	1.181	0.3	0.2	0	46	38.7	0	140	123	0	33	33	33
2025	10	3	2	20	30	30.1	-3.4	1.181	0.4	0.3	0	45.6	38.7	0	140	123	0	34	33	33
2025	10	3	2	30	30	28.9	-2.6	1.181	0.3	0.2	0	46	39.1	0	141	123	0	34	32	33
2025	10	3	2	40	30	29	-3	1.182	0.3	0.2	0	46.9	39.6	0	141	124	0	32	32	33
2025	10	3	2	50	30	28.8	-3.4	1.181	0.4	0.3	0	46	39.6	0	140	124	0	33	32	32
2025	10	3	3	0	30	29.5	-3.1	1.182	0.3	0.2	0	46	39.1	0	140	123	0	33	32	33
2025	10	3	3	10	30	28.9	-2.2	1.183	0.4	0.3	0	46	39.1	0	140	123	0	33	32	33
2025	10	3	3	20	30	30.5	-3	1.182	0.4	0.3	0	46	39.6	0	140	124	0	33	32	34
2025	10	3	3	30	30	29	-2	1.183	0.3	0.2	0	45.6	39.6	0	140	124	0	34	32	33
2025	10	3	3	40	30	29.7	-2.6	1.183	0.5	0.4	0	46	39.1	0	140	124	0	33	33	33
2025	10	3	3	50	30	29.8	-2.3	1.183	0.4	0.3	0	46	39.6	0	140	124	0	33	32	33
2025	10	3	4	0	30	28.9	-1.9	1.181	0.3	0.2	0	46	39.1	0	140	123	0	33	32	32
2025	10	3	4	10	30	29.3	-2.7	1.183	0.4	0.3	0	45.6	39.1	0	140	124	0	34	33	33
2025	10	3	4	20	30	29	-3.5	1.183	0.4	0.3	0	46	39.1	0	140	123	0	33	32	33
2025	10	3	4	30	30	30	-1.7	1.183	0.3	0.2	0	46	38.7	0	140	123	0	33	33	32
2025	10	3	4	40	30	28.8	-2.6	1.184	0.4	0.3	0	46	39.1	0	140	123	0	33	32	33
2025	10	3	4	50	30	29.8	-3	1.183	0.4	0.3	0	45.6	39.1	0	139	123	0	33	32	33
2025	10	3	5	0	30	28.3	-2.6	1.183	0.5	0.4	0	45.6	39.1	0	139	123	0	33	32	32
2025	10	3	5	10	30	30.2	-2.2	1.185	0.3	0.2	0	45.6	39.1	0	139	123	0	33	32	33
2025	10	3	5	20	30	29.8	-3.5	1.186	0.3	0.2	0	45.6	38.7	0	139	122	0	33	32	33
2025	10	3	5	30	30	30.9	-2.9	1.186	0.3	0.2	0	45.2	38.7	0	139	122	0	34	32	33
2025	10	3	5	40	30	30.7	-1.8	1.186	0.3	0.2	0	44.7	38.7	0	138	122	0	34	32	33
2025	10	3	5	50	30	29.4	-2.4	1.186	0.5	0.4	0	45.6	38.7	0	139	123	0	33	33	33
2025	10	3	6	0	30	28.8	-1.4	1.186	0.3	0.2	0	45.6	39.6	0	140	124	0	34	32	33
2025	10	3	6	10	30	29.4	-1.4	1.186	0.3	0.2	0	46	39.1	0	140	123	0	33	32	33
2025	10	3	6	20	30	28.9	-1	1.186	0.3	0.2	0	46	39.1	0	140	123	0	33	32	33
2025	10	3	6	30	30	27.5	-1.8	1.186	0.3	0.2	0	46	39.6	0	140	124	0	33	32	33
2025	10	3	6	40	30	30.4	-1.6	1.186	0.4	0.3	0	45.6	39.1	0	139	123	0	33	32	33
2025	10	3	6	50	30	28.3	-2.1	1.186	0.3	0.2	0	45.2	39.1	0	139	123	0	34	32	33
2025	10	3	7	0	30	29.9	-3.2	1.186	0.3	0.2	0	45.2	37.8	0	138	122	0	33	34	33
2025	10	3	7	10	30	28.2	-1	1.186	0.4	0.3	0	45.2	38.7	0	138	122	0	33	32	33
2025	10	3	7	20	30	30.4	-4	1.186	0.4	0.3	0	44.7	38.3	0	137	121	0	33	32	32
2025	10	3	7	30	30	28.8	-1.3	1.186	0.3	0.2	0	44.3	38.3	0	137	121	0	34	32	33
2025	10	3	7	40	30	29.3	-1.4	1.186	0.3	0.2	0	45.2	38.3	0	138	121	0	33	32	33
2025	10	3	7	50	30	30.4	-2.6	1.186	0.3	0.2	0	45.2	38.3	0	137	121	0	32	32	32

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	3	8	0	30	29.3	-2.5	1.187	0.3	0.2	0	44.3	38.3	0	137	121	0	34	32	33
2025	10	3	8	10	30	28.6	-2.3	1.187	0.5	0.4	0	43.9	38.3	0	136	120	0	34	31	33
2025	10	3	8	20	30	30.3	-2.5	1.187	0.5	0.4	0	43.9	37.8	0	136	120	0	34	32	34
2025	10	3	8	30	30	30.1	-3	1.187	0.3	0.2	0	43.9	37.8	0	136	120	0	34	32	33
2025	10	3	8	40	30	30.6	-3.1	1.187	0.4	0.3	0	44.3	37.4	0	135	119	0	32	32	32
2025	10	3	8	50	30	28.9	-1.8	1.187	0.4	0.3	0	44.3	37.8	0	136	120	0	33	32	34
2025	10	3	9	0	30	29.3	-2.6	1.187	0.3	0.2	0	43.9	37.4	0	135	119	0	33	32	33
2025	10	3	9	10	30	30.1	-2.9	1.187	0.3	0.2	0	43.9	37	0	135	119	0	33	33	33
2025	10	3	9	20	30	28.9	-3.4	1.187	0.3	0.2	0	43.9	37.4	0	135	119	0	33	32	32
2025	10	3	9	30	30	28.9	-2.2	1.187	0.3	0.2	0	43.4	37.4	0	135	119	0	34	32	33
2025	10	3	9	40	30	29.3	-2.3	1.187	0.4	0.3	0	43.4	37.8	0	135	119	0	34	31	32
2025	10	3	9	50	30	30.2	-2.6	1.188	0.4	0.3	0	43.9	37.4	0	135	119	0	33	32	33
2025	10	3	10	0	30	29.2	-2.8	1.188	0.4	0.3	0	43.4	37.4	0	135	119	0	34	32	33
2025	10	3	10	10	30	29.5	-3	1.188	0.3	0.2	0	44.3	37.4	0	135	119	0	32	32	32
2025	10	3	10	20	30	29.5	-3	1.188	0.5	0.4	0	43.9	37.4	0	135	119	0	33	32	32
2025	10	3	10	30	30	29.9	-4.4	1.188	0.4	0.3	0	43.4	37.4	0	135	119	0	34	32	33
2025	10	3	10	40	30	29.6	-2.4	1.187	0.5	0.4	0	43.9	37.8	0	135	119	0	33	31	32
2025	10	3	10	50	30	29.3	-3.2	1.188	0.4	0.3	0	43.9	37.4	0	135	119	0	33	32	33
2025	10	3	11	0	30	30.1	-3.1	1.188	0.3	0.2	0	43.4	37.4	0	134	119	0	33	32	33
2025	10	3	11	10	30	30.1	-2.6	1.188	0.3	0.2	0	43.4	37	0	134	118	0	33	32	33
2025	10	3	11	20	30	29.4	-4.5	1.187	0.3	0.2	0	43	37.4	0	134	119	0	34	32	33
2025	10	3	11	30	30	28.8	-1.8	1.188	0.5	0.4	0	43.4	38.3	0	135	120	0	34	31	33
2025	10	3	11	40	30	29.8	-3.6	1.187	0.3	0.2	0	43.4	37.4	0	134	119	0	33	32	33
2025	10	3	11	50	30	29.2	-4.1	1.188	0.3	0.2	0	43.9	37.4	0	134	119	0	32	32	33
2025	10	3	12	0	30	29.2	-2.2	1.188	0.3	0.2	0	43.9	38.3	0	135	120	0	33	31	33
2025	10	3	12	10	30	29.5	-1.8	1.189	0.4	0.3	0	43.9	37.8	0	135	120	0	33	32	33
2025	10	3	12	20	30	29.3	-1.8	1.188	0.4	0.3	0	44.3	37.8	0	136	120	0	33	32	33
2025	10	3	12	30	30	29.6	-2.7	1.188	0.3	0.2	0	43.9	37.4	0	135	119	0	33	32	33
2025	10	3	12	40	30	29.9	-2.5	1.188	0.3	0.2	0	43.9	37.8	0	136	120	0	34	32	33
2025	10	3	12	50	30	29.9	-2	1.188	0.3	0.2	0	44.3	38.3	0	136	120	0	33	31	33
2025	10	3	13	0	30	30	-2.8	1.188	0.4	0.3	0	43.9	37.8	0	136	120	0	34	32	33
2025	10	3	13	10	30	29.9	-2.2	1.188	0.4	0.3	0	44.3	37.4	0	136	119	0	33	32	32
2025	10	3	13	20	30	29.6	-1.6	1.188	0.4	0.3	0	44.7	38.3	0	137	121	0	33	32	33
2025	10	3	13	30	30	29.4	-3.1	1.188	0.4	0.3	0	43.9	37.8	0	136	120	0	34	32	33
2025	10	3	13	40	30	29.7	-3.1	1.188	0.4	0.3	0	44.3	37.8	0	136	120	0	33	32	33
2025	10	3	13	50	30	30	-2.8	1.188	0.3	0.2	0	43.9	37	0	135	119	0	33	33	33
2025	10	3	14	0	30	29.9	-2.8	1.188	0.3	0.2	0	43.4	37.8	0	135	119	0	34	31	33
2025	10	3	14	10	30	29.4	-2.9	1.188	0.3	0.2	0	43	37	0	134	118	0	34	32	33
2025	10	3	14	20	30	29.9	-3.4	1.187	0.4	0.3	0	43.4	36.5	0	134	117	0	33	32	33
2025	10	3	14	30	30	29.9	-2.8	1.188	0.3	0.2	0	43.9	37	0	135	119	0	33	33	32
2025	10	3	14	40	30	29.7	-2.5	1.188	0.3	0.2	0	43.4	37.4	0	135	119	0	34	32	33
2025	10	3	14	50	30	29	-1.9	1.188	0.3	0.2	0	43.9	37.4	0	135	119	0	33	32	33
2025	10	3	15	0	30	28.9	-2.4	1.188	0.3	0.2	0	43.9	37.8	0	135	120	0	33	32	33
2025	10	3	15	10	30	29.6	-1.4	1.187	0.5	0.4	0	43.9	37.4	0	135	119	0	33	32	33
2025	10	3	15	20	30	30	-2.5	1.187	0.4	0.3	0	43.4	37	0	135	118	0	34	32	32
2025	10	3	15	30	30	28.9	-3	1.187	0.4	0.3	0	43.9	37.4	0	135	119	0	33	32	32
2025	10	3	15	40	30	29.9	-2.2	1.187	0.3	0.2	0	43.9	37.8	0	135	119	0	33	31	32
2025	10	3	15	50	30	30.3	-2.6	1.187	0.3	0.2	0	43.9	37.4	0	136	119	0	34	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	3	16	0	30	29.4	-2.2	1.187	0.3	0.2	0	44.3	37.8	0	136	120	0	33	32	33
2025	10	3	16	10	30	30.1	-2.4	1.187	0.3	0.2	0	43.9	37	0	136	119	0	34	33	34
2025	10	3	16	20	30	29.7	-2	1.187	0.4	0.3	0	44.7	37.8	0	137	120	0	33	32	33
2025	10	3	16	30	30	30.3	-3.5	1.187	0.4	0.3	0	44.3	38.3	0	137	121	0	34	32	33
2025	10	3	16	40	30	29.5	-2.3	1.187	0.3	0.2	0	44.7	38.3	0	138	121	0	34	32	33
2025	10	3	16	50	30	29.5	-1.8	1.187	0.4	0.3	0	45.2	39.1	0	139	123	0	34	32	32
2025	10	3	17	0	30	29.4	-3.6	1.187	0.3	0.2	0	45.2	38.7	0	139	122	0	34	32	33
2025	10	3	17	10	30	29.1	-3.5	1.187	0.4	0.3	0	45.6	38.7	0	140	122	0	34	32	33
2025	10	3	17	20	30	29.5	-2.3	1.187	0.3	0.2	0	45.6	38.7	0	139	122	0	33	32	33
2025	10	3	17	30	30	29.1	-2.7	1.187	0.3	0.2	0	45.6	38.7	0	139	122	0	33	32	33
2025	10	3	17	40	30	29.3	-2.6	1.187	0.4	0.3	0	45.6	38.7	0	139	122	0	33	32	33
2025	10	3	17	50	30	28.6	-2.4	1.187	0.5	0.4	0	45.6	38.3	0	139	121	0	33	32	33
2025	10	3	18	0	30	29.4	-3.4	1.187	0.4	0.3	0	45.6	38.7	0	139	122	0	33	32	32
2025	10	3	18	10	30	29.5	-2.6	1.187	0.5	0.4	0	45.2	38.7	0	139	122	0	34	32	33
2025	10	3	18	20	30	29.7	-1.9	1.187	0.3	0.2	0	45.6	38.7	0	139	122	0	33	32	33
2025	10	3	18	30	30	28.3	-2.1	1.187	0.3	0.2	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	3	18	40	30	29.9	-1.9	1.187	0.3	0.2	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	3	18	50	30	29	-2.5	1.187	0.4	0.3	0	46.4	38.7	0	141	122	0	33	32	32
2025	10	3	19	0	30	30	-2.8	1.187	0.5	0.5	0	46.4	38.7	0	142	122	0	34	32	33
2025	10	3	19	10	30	28.9	-2.6	1.187	0.4	0.3	0	46.4	39.6	0	142	123	0	34	31	33
2025	10	3	19	20	30	29.2	-2.9	1.187	0.3	0.2	0	46.9	39.1	0	142	123	0	33	32	33
2025	10	3	19	30	30	29.4	-3.6	1.187	0.3	0.2	0	46.4	39.1	0	142	123	0	34	32	33
2025	10	3	19	40	30	29.6	-2.8	1.187	0.4	0.3	0	46.9	39.1	0	142	123	0	33	32	33
2025	10	3	19	50	30	28.6	-2.7	1.187	0.3	0.2	0	46.9	39.1	0	142	123	0	33	32	34
2025	10	3	20	0	30	28.9	-2.7	1.187	0.3	0.2	0	46.4	39.1	0	142	123	0	34	32	33
2025	10	3	20	10	30	29.2	-2.2	1.187	0.3	0.2	0	46.9	39.1	0	142	123	0	33	32	33
2025	10	3	20	20	30	29.8	-2.6	1.187	0.4	0.3	0	46.4	39.1	0	142	123	0	34	32	33
2025	10	3	20	30	30	30.2	-2.7	1.187	0.5	0.5	0	46.4	38.7	0	141	122	0	33	32	32
2025	10	3	20	40	30	28.6	-2.1	1.186	0.4	0.3	0	46.9	39.1	0	142	123	0	33	32	33
2025	10	3	20	50	30	30.9	-2.4	1.186	0.3	0.2	0	46.4	38.7	0	141	122	0	33	32	32
2025	10	3	21	0	30	29	-3.6	1.186	0.4	0.3	0	46.9	39.1	0	142	123	0	33	32	33
2025	10	3	21	10	30	30.4	-2.4	1.186	0.4	0.3	0	46.4	39.6	0	141	123	0	33	31	33
2025	10	3	21	20	30	29.6	-3.3	1.186	0.4	0.3	0	46	39.1	0	141	123	0	34	32	33
2025	10	3	21	30	30	29.3	-2.8	1.186	0.3	0.2	0	46	39.1	0	140	123	0	33	32	33
2025	10	3	21	40	30	29.2	-0.9	1.187	0.4	0.3	0	46.9	39.6	0	142	124	0	33	32	33
2025	10	3	21	50	30	29.2	-2.7	1.186	0.4	0.3	0	46.4	38.7	0	141	123	0	33	33	33
2025	10	3	22	0	30	30.1	-3.1	1.187	0.4	0.3	0	46	38.7	0	141	122	0	34	32	33
2025	10	3	22	10	30	29	-2	1.187	0.5	0.4	0	46	38.3	0	141	122	0	34	33	33
2025	10	3	22	20	30	30.5	-1.5	1.187	0.5	0.4	0	46.4	38.3	0	141	122	0	33	33	33
2025	10	3	22	30	30	29	-2.5	1.187	0.4	0.3	0	46	38.3	0	140	122	0	33	33	33
2025	10	3	22	40	30	29	-2.7	1.187	0.5	0.4	0	46	38.7	0	140	122	0	33	32	34
2025	10	3	22	50	30	29.1	-1.3	1.187	0.3	0.2	0	46	39.6	0	141	123	0	34	31	33
2025	10	3	23	0	30	29.3	-3	1.187	0.3	0.2	0	46.4	39.1	0	141	123	0	33	32	34
2025	10	3	23	10	30	28.6	-1.9	1.186	0.3	0.2	0	45.6	38.7	0	140	122	0	34	32	33
2025	10	3	23	20	30	30	-3.3	1.187	0.4	0.3	0	45.6	38.3	0	140	122	0	34	33	33
2025	10	3	23	30	30	29.3	-2.7	1.186	0.3	0.2	0	46	38.7	0	140	122	0	33	32	33
2025	10	3	23	40	30	29.4	-2.2	1.186	0.4	0.3	0	46	38.7	0	140	122	0	33	32	33
2025	10	3	23	50	30	28.2	-1.7	1.186	0.3	0.2	0	45.6	38.7	0	140	122	0	34	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	4	0	0	30	30.3	-2.5	1.186	0.3	0.2	0	45.6	39.1	0	140	123	0	34	32	33
2025	10	4	0	10	30	27.8	-2.7	1.186	0.3	0.2	0	46	38.7	0	140	122	0	33	32	33
2025	10	4	0	20	30	30	-2.6	1.186	0.4	0.3	0	46.4	38.7	0	140	122	0	32	32	33
2025	10	4	0	30	30	28.8	-2.7	1.186	0.5	0.4	0	45.6	38.7	0	139	122	0	33	32	33
2025	10	4	0	40	30	30	-2.5	1.186	0.5	0.4	0	45.2	38.7	0	139	122	0	34	32	33
2025	10	4	0	50	30	29.4	-2.1	1.186	0.3	0.2	0	45.2	38.3	0	139	122	0	34	33	32
2025	10	4	1	0	30	29.5	-1.8	1.186	0.3	0.2	0	46	39.1	0	140	122	0	33	31	34
2025	10	4	1	10	30	29	-3	1.186	0.4	0.3	0	45.2	38.3	0	139	122	0	34	33	33
2025	10	4	1	20	30	29.8	-3.5	1.186	0.4	0.3	0	45.2	38.7	0	139	122	0	34	32	33
2025	10	4	1	30	30	29.8	-2.6	1.186	0.5	0.4	0	46	38.3	0	141	122	0	34	33	33
2025	10	4	1	40	30	29.7	-2.7	1.186	0.4	0.3	0	46.4	38.3	0	141	121	0	33	32	33
2025	10	4	1	50	30	28.8	-2.8	1.186	0.3	0.2	0	46.9	38.7	0	142	122	0	33	32	32
2025	10	4	2	0	30	29.2	-2.7	1.186	0.4	0.3	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	4	2	10	30	30.4	-2.7	1.186	0.5	0.4	0	46	37.8	0	141	121	0	34	33	33
2025	10	4	2	20	30	29	-2.5	1.186	0.4	0.3	0	46.4	38.7	0	142	122	0	34	32	33
2025	10	4	2	30	30	30.5	-2.5	1.186	0.4	0.3	0	45.6	38.3	0	140	121	0	34	32	33
2025	10	4	2	40	30	30.1	-3.5	1.186	0.5	0.5	0	46	37.8	0	140	121	0	33	33	33
2025	10	4	2	50	30	29	-3.3	1.186	0.3	0.2	0	46	38.7	0	140	121	0	33	31	33
2025	10	4	3	0	30	30.3	-2.6	1.186	0.4	0.3	0	46	38.3	0	140	121	0	33	32	33
2025	10	4	3	10	30	30.2	-2.6	1.186	0.3	0.2	0	46	38.3	0	140	121	0	33	32	33
2025	10	4	3	20	30	28.4	-2.2	1.186	0.3	0.2	0	46	38.3	0	141	121	0	34	32	33
2025	10	4	3	30	30	29.1	-2.1	1.186	0.4	0.3	0	46	38.3	0	141	121	0	34	32	33
2025	10	4	3	40	30	29.5	-3.1	1.186	0.3	0.2	0	45.6	38.3	0	140	121	0	34	32	32
2025	10	4	3	50	30	28.6	-3.1	1.186	0.3	0.2	0	45.6	37.8	0	140	121	0	34	33	32
2025	10	4	4	0	30	29.5	-3.1	1.186	0.4	0.3	0	45.6	37.8	0	140	121	0	34	33	34
2025	10	4	4	10	30	28.7	-2.2	1.186	0.3	0.2	0	46	38.3	0	140	121	0	33	32	33
2025	10	4	4	20	30	29.6	-3.3	1.186	0.4	0.3	0	45.2	37.4	0	139	120	0	34	33	33
2025	10	4	4	30	30	30.4	-4.3	1.186	0.3	0.2	0	46	38.3	0	140	121	0	33	32	34
2025	10	4	4	40	30	30.3	-2.3	1.186	0.4	0.3	0	45.6	38.3	0	140	121	0	34	32	32
2025	10	4	4	50	30	29.7	-3.5	1.185	0.3	0.2	0	45.6	38.3	0	139	121	0	33	32	33
2025	10	4	5	0	30	29.1	-2.9	1.186	0.3	0.2	0	46	38.3	0	140	121	0	33	32	33
2025	10	4	5	10	30	30	-1.8	1.185	0.4	0.3	0	45.2	37.8	0	139	120	0	34	32	33
2025	10	4	5	20	30	29.5	-3.4	1.185	0.4	0.3	0	45.6	38.3	0	140	121	0	34	32	33
2025	10	4	5	30	30	30.3	-3.1	1.185	0.5	0.4	0	45.6	38.3	0	139	120	0	33	31	34
2025	10	4	5	40	30	29.4	-3.3	1.185	0.4	0.3	0	45.2	37.8	0	139	120	0	34	32	33
2025	10	4	5	50	30	29.9	-3.5	1.185	0.4	0.3	0	45.2	37.8	0	139	120	0	34	32	33
2025	10	4	6	0	30	28.8	-3	1.185	0.4	0.3	0	45.6	37.8	0	140	121	0	34	33	33
2025	10	4	6	10	30	29.6	-2.5	1.185	0.3	0.2	0	45.6	37.8	0	139	120	0	33	32	33
2025	10	4	6	20	30	29.4	-2.7	1.185	0.4	0.3	0	45.6	38.3	0	139	120	0	33	31	32
2025	10	4	6	30	30	30.3	-2.9	1.185	0.4	0.3	0	44.7	37.8	0	138	120	0	34	32	33
2025	10	4	6	40	30	30.6	-2.6	1.185	0.3	0.2	0	44.7	37	0	138	119	0	34	33	33
2025	10	4	6	50	30	31.4	-2.6	1.185	0.3	0.2	0	44.3	37	0	137	119	0	34	33	33
2025	10	4	7	0	30	29	-1.4	1.185	0.5	0.4	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	4	7	10	30	30.6	-3.1	1.185	0.4	0.3	0	44.3	37	0	137	118	0	34	32	34
2025	10	4	7	20	30	29.3	-3.1	1.185	0.3	0.2	0	44.7	37.4	0	137	118	0	33	31	33
2025	10	4	7	30	30	29.5	-2.9	1.185	0.3	0.2	0	44.3	36.5	0	136	118	0	33	33	33
2025	10	4	7	40	30	29.4	-2.9	1.185	0.4	0.3	0	43.9	35.7	0	135	116	0	33	33	33
2025	10	4	7	50	30	29.9	-1.6	1.185	0.3	0.2	0	43.9	36.1	0	135	116	0	33	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	4	8	0	30	29.2	-2.4	1.185	0.3	0.2	0	43.4	35.7	0	135	116	0	34	33	33
2025	10	4	8	10	30	29.5	-2.6	1.185	0.3	0.2	0	43.4	36.1	0	135	116	0	34	32	33
2025	10	4	8	20	30	29.3	-3.3	1.185	0.3	0.2	0	43	36.1	0	134	116	0	34	32	33
2025	10	4	8	30	30	29.3	-2.5	1.185	0.4	0.3	0	43.4	35.7	0	134	115	0	33	32	33
2025	10	4	8	40	30	28	-2.8	1.185	0.3	0.2	0	43	35.3	0	133	115	0	33	33	33
2025	10	4	8	50	30	27.2	-2.2	1.185	0.3	0.2	0	43.4	35.7	0	134	115	0	33	32	33
2025	10	4	9	0	30	28.5	-2.1	1.185	0.3	0.2	0	42.6	35.3	0	133	114	0	34	32	33
2025	10	4	9	10	30	29.8	-2.3	1.185	0.3	0.2	0	42.6	35.3	0	133	115	0	34	33	33
2025	10	4	9	20	30	29.2	-1.8	1.185	0.5	0.4	0	42.6	35.3	0	133	114	0	34	32	33
2025	10	4	9	30	30	29.5	-2.6	1.185	0.4	0.3	0	42.1	34.8	0	132	114	0	34	33	33
2025	10	4	9	40	30	30.4	-2.5	1.185	0.3	0.2	0	42.1	35.3	0	132	114	0	34	32	33
2025	10	4	9	50	30	29.4	-2.4	1.185	0.5	0.4	0	42.6	34.8	0	132	114	0	33	33	33
2025	10	4	10	0	30	29	-2.1	1.185	0.3	0.2	0	42.6	35.3	0	133	115	0	34	33	33
2025	10	4	10	10	30	28.7	-2.4	1.185	0.3	0.2	0	43	35.7	0	133	115	0	33	32	34
2025	10	4	10	20	30	28.7	-2.4	1.185	0.3	0.2	0	42.6	35.7	0	133	115	0	34	32	33
2025	10	4	10	30	30	29.6	-3.1	1.185	0.3	0.2	0	43	35.7	0	133	115	0	33	32	34
2025	10	4	10	40	30	29.7	-2.9	1.185	0.4	0.3	0	42.6	35.7	0	133	115	0	34	32	33
2025	10	4	10	50	30	29.5	-4	1.185	0.4	0.3	0	43	35.3	0	133	115	0	33	33	33
2025	10	4	11	0	30	28.7	-3.1	1.184	0.3	0.2	0	42.1	35.7	0	132	115	0	34	32	33
2025	10	4	11	10	30	28.6	-2.2	1.184	0.4	0.3	0	42.1	35.3	0	132	115	0	34	33	34
2025	10	4	11	20	30	29.3	-2	1.184	0.4	0.3	0	42.1	35.7	0	132	115	0	34	32	34
2025	10	4	11	30	30	28.8	-3.5	1.184	0.3	0.2	0	42.1	35.3	0	132	114	0	34	32	33
2025	10	4	11	40	30	28.6	-2.3	1.184	0.3	0.2	0	42.1	35.3	0	131	114	0	33	32	33
2025	10	4	11	50	30	28.6	-3.3	1.184	0.5	0.4	0	41.7	34.8	0	131	114	0	34	33	33
2025	10	4	12	0	30	29.2	-3.4	1.184	0.3	0.2	0	41.7	34.8	0	131	113	0	34	32	33
2025	10	4	12	10	30	29.6	-2.5	1.185	0.4	0.3	0	42.1	35.3	0	131	114	0	33	32	34
2025	10	4	12	20	30	28.1	-2.6	1.184	0.3	0.2	0	42.1	35.3	0	132	114	0	34	32	33
2025	10	4	12	30	30	29.1	-2.7	1.184	0.3	0.2	0	42.1	35.3	0	131	114	0	33	32	34
2025	10	4	12	40	30	29.7	-3.2	1.184	0.4	0.3	0	42.6	35.3	0	132	114	0	33	32	33
2025	10	4	12	50	30	28.8	-2.2	1.184	0.3	0.2	0	41.7	34.8	0	131	113	0	34	32	33
2025	10	4	13	0	30	28.3	-2.8	1.184	0.4	0.3	0	42.1	34.8	0	131	113	0	33	32	34
2025	10	4	13	10	30	29.6	-3	1.184	0.3	0.2	0	42.6	35.3	0	132	114	0	33	32	33
2025	10	4	13	20	30	28.3	-2.7	1.184	0.3	0.2	0	41.7	35.3	0	131	114	0	34	32	32
2025	10	4	13	30	30	29.1	-2.3	1.184	0.3	0.2	0	41.7	35.3	0	131	114	0	34	32	34
2025	10	4	13	40	30	30.3	-2.9	1.184	0.3	0.2	0	41.7	34.8	0	131	113	0	34	32	34
2025	10	4	13	50	30	29	-2.3	1.184	0.4	0.3	0	41.7	35.3	0	131	114	0	34	32	34
2025	10	4	14	0	30	30	-2.8	1.184	0.4	0.3	0	42.1	35.3	0	131	114	0	33	32	33
2025	10	4	14	10	30	28.5	-1.7	1.184	0.4	0.3	0	42.1	34.8	0	131	113	0	33	32	33
2025	10	4	14	20	30	29.5	-3.6	1.184	0.4	0.3	0	41.7	35.3	0	131	114	0	34	32	33
2025	10	4	14	30	30	30.1	-3.1	1.184	0.4	0.3	0	42.1	34.8	0	132	114	0	34	33	33
2025	10	4	14	40	30	28.7	-2.2	1.184	0.4	0.3	0	42.6	35.3	0	132	114	0	33	32	33
2025	10	4	14	50	30	30	-3.2	1.184	0.4	0.3	0	41.7	34.8	0	131	114	0	34	33	34
2025	10	4	15	0	30	30.2	-3.4	1.184	0.4	0.3	0	42.6	35.3	0	132	114	0	33	32	32
2025	10	4	15	10	30	30.6	-2.5	1.184	0.3	0.2	0	41.7	35.3	0	131	114	0	34	32	34
2025	10	4	15	20	30	29.2	-1.9	1.183	0.4	0.3	0	42.6	34.8	0	132	114	0	33	33	33
2025	10	4	15	30	30	29.9	-2.4	1.183	0.4	0.3	0	42.1	34.8	0	132	114	0	34	33	33
2025	10	4	15	40	30	28.7	-2.9	1.183	0.3	0.2	0	42.1	34.8	0	132	114	0	34	33	34
2025	10	4	15	50	30	29.2	-2.9	1.183	0.3	0.2	0	42.1	35.7	0	132	115	0	34	32	33

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	10	4	16	0	30	29.1	-2.1	1.183	0.3	0.2	0	42.6	35.7	0	132	114	0	33	31	33	
2025	10	4	16	10	30	29.4	-2.7	1.183	0.3	0.2	0	42.1	34.8	0	132	114	0	34	33	33	
2025	10	4	16	20	30	29	-1.5	1.183	0.3	0.2	0	43	35.7	0	133	115	0	33	32	33	
2025	10	4	16	30	30	30.2	-2.7	1.183	0.3	0.2	0	42.6	36.1	0	133	116	0	34	32	32	
2025	10	4	16	40	30	30.5	-2.7	1.183	0.3	0.2	0	42.1	34.8	0	132	114	0	34	33	33	
2025	10	4	16	50	30	29.3	-3	1.183	0.3	0.2	0	42.1	35.3	0	132	114	0	34	32	33	
2025	10	4	17	0	30	29.4	-3.7	1.183	0.4	0.3	0	42.1	34.8	0	131	113	0	33	32	34	
2025	10	4	17	10	30	29	-3	1.182	0.3	0.2	0	42.6	35.3	0	132	114	0	33	32	33	
2025	10	4	17	20	30	30	-2.9	1.182	0.4	0.3	0	42.6	35.3	0	132	114	0	33	32	34	
2025	10	4	17	30	30	29.9	-4.1	1.182	0.4	0.3	0	42.6	34.8	0	132	113	0	33	32	33	
2025	10	4	17	40	30	29.8	-2.6	1.182	0.5	0.4	0	42.6	34.8	0	132	114	0	33	33	33	
2025	10	4	17	50	30	29.6	-3	1.182	0.3	0.2	0	42.1	35.7	0	132	114	0	34	31	33	
2025	10	4	18	0	30	30.2	-3.4	1.182	0.5	0.5	0	42.6	34.8	0	132	114	0	33	33	32	
2025	10	4	18	10	30	29.6	-2.6	1.182	0.3	0.2	0	42.6	35.7	0	133	115	0	34	32	32	
2025	10	4	18	20	30	29.8	-3.7	1.182	0.3	0.2	0	43	35.7	0	133	115	0	33	32	34	
2025	10	4	18	30	30	29.3	-3.5	1.182	0.3	0.2	0	43	35.7	0	133	115	0	33	32	33	
2025	10	4	18	40	30	30.4	-2.5	1.182	0.4	0.3	0	43.4	35.3	0	134	115	0	33	33	34	
2025	10	4	18	50	30	29	-3.1	1.182	0.3	0.2	0	43.9	36.1	0	135	116	0	33	32	33	
2025	10	4	19	0	30	29	-2.9	1.182	0.5	0.4	0	43.4	36.5	0	135	117	0	34	32	33	
2025	10	4	19	10	30	29.3	-3.5	1.182	0.5	0.4	0	43.9	36.1	0	135	117	0	33	33	33	
2025	10	4	19	20	30	29.1	-3.8	1.182	0.5	0.4	0	43.9	36.5	0	135	117	0	33	32	33	
2025	10	4	19	30	30	29.5	-3.5	1.182	0.5	0.4	0	44.3	36.5	0	136	118	0	33	33	33	
2025	10	4	19	40	30	29.6	-3.6	1.182	0.4	0.3	0	44.3	37.4	0	137	119	0	34	32	33	
2025	10	4	19	50	30	29.9	-2.9	1.182	0.5	0.4	0	44.3	37	0	137	119	0	34	33	33	
2025	10	4	20	0	30	28.9	-3.3	1.182	0.4	0.3	0	44.3	37.4	0	137	118	0	34	31	33	
2025	10	4	20	10	30	29.7	-3.1	1.182	0.4	0.3	0	44.3	37	0	137	118	0	34	32	32	
2025	10	4	20	20	30	29.2	-1.9	1.182	0.3	0.2	0	44.3	37	0	137	119	0	34	33	34	
2025	10	4	20	30	30	30	-3.4	1.182	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33	
2025	10	4	20	40	30	29	-2.7	1.182	0.3	0.2	0	44.7	37	0	138	119	0	34	33	34	
2025	10	4	20	50	30	29.5	-2.4	1.182	0.5	0.4	0	44.7	37.4	0	138	119	0	34	32	34	
2025	10	4	21	0	30	28.8	-3.3	1.182	0.4	0.3	0	44.3	37.4	0	137	119	0	34	32	33	
2025	10	4	21	10	30	29.7	-2.6	1.182	0.4	0.3	0	44.3	37.4	0	137	119	0	34	32	33	
2025	10	4	21	20	30	29	-3.9	1.182	0.3	0.2	0	44.7	37	0	137	119	0	33	33	33	
2025	10	4	21	30	30	28	-3.1	1.182	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33	
2025	10	4	21	40	30	30	-3.5	1.182	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33	
2025	10	4	21	50	30	29.1	-2.8	1.182	0.4	0.3	0	44.7	37.4	0	138	119	0	34	32	34	
2025	10	4	22	0	30	28.8	-2	1.182	0.3	0.2	0	44.7	37.8	0	138	120	0	34	32	34	
2025	10	4	22	10	30	30.2	-2	1.182	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33	
2025	10	4	22	20	30	30.1	-3	1.182	0.4	0.3	0	44.3	37.4	0	137	119	0	34	32	33	
2025	10	4	22	30	30	27.6	-2.4	1.182	0.4	0.3	0	44.7	37.4	0	137	119	0	33	32	33	
2025	10	4	22	40	30	29.1	-3.6	1.182	0.3	0.2	0	44.7	37.4	0	137	119	0	33	32	33	
2025	10	4	22	50	30	29.2	-2.2	1.182	0.3	0.2	0	44.7	37	0	138	119	0	34	33	33	
2025	10	4	23	0	30	29.8	-3.2	1.182	0.4	0.3	0	45.2	37.4	0	138	119	0	33	32	33	
2025	10	4	23	10	30	30.3	-1.7	1.182	0.3	0.2	0	45.2	37.4	0	138	120	0	33	33	33	
2025	10	4	23	20	30	28.8	-2.6	1.182	0.5	0.5	0	44.3	37	0	137	119	0	34	33	33	
2025	10	4	23	30	30	28.8	-3.4	1.182	0.4	0.3	0	44.7	37	0	137	119	0	33	33	33	
2025	10	4	23	40	30	29.6	-2.3	1.182	0.4	0.3	0	44.7	37	0	137	119	0	33	33	33	
2025	10	4	23	50	30	27.9	-2.3	1.182	0.3	0.2	0	44.3	37	0	137	119	0	34	33	34	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	5	0	0	30	29.4	-3.1	1.182	0.5	0.4	0	43.9	36.5	0	136	118	0	34	33	33
2025	10	5	0	10	30	28.6	-2.8	1.182	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	34
2025	10	5	0	20	30	28.4	-2	1.182	0.3	0.2	0	44.7	37	0	138	119	0	34	33	33
2025	10	5	0	30	30	28.9	-2.8	1.182	0.3	0.2	0	44.7	37.4	0	137	119	0	33	32	34
2025	10	5	0	40	30	29.8	-3.1	1.182	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	5	0	50	30	28.3	-2.5	1.182	0.4	0.3	0	44.3	37	0	137	119	0	34	33	33
2025	10	5	1	0	30	28.6	-1.8	1.182	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	34
2025	10	5	1	10	30	28	-2.6	1.182	0.3	0.2	0	44.7	37	0	137	119	0	33	33	33
2025	10	5	1	20	30	29.8	-2.8	1.182	0.3	0.2	0	44.7	37	0	137	119	0	33	33	33
2025	10	5	1	30	30	29.7	-3	1.182	0.3	0.2	0	44.3	37	0	137	119	0	34	33	33
2025	10	5	1	40	30	29.7	-3	1.182	0.3	0.2	0	43.9	36.5	0	136	118	0	34	33	33
2025	10	5	1	50	30	29.5	-2.7	1.182	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	5	2	0	30	29.3	-2.4	1.182	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	5	2	10	30	29.6	-3.3	1.182	0.4	0.3	0	44.7	37	0	137	119	0	33	33	34
2025	10	5	2	20	30	30.1	-3.5	1.182	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	5	2	30	30	28.8	-2.9	1.182	0.3	0.2	0	44.7	37.4	0	137	119	0	33	32	33
2025	10	5	2	40	30	30.2	-2.8	1.182	0.3	0.2	0	44.3	37	0	136	119	0	33	33	34
2025	10	5	2	50	30	30.3	-2.1	1.182	0.3	0.2	0	44.3	37	0	137	119	0	34	33	33
2025	10	5	3	0	30	29.7	-3	1.182	0.3	0.2	0	44.3	37	0	137	119	0	34	33	34
2025	10	5	3	10	30	28.3	-1.7	1.182	0.5	0.5	0	44.3	37	0	137	119	0	34	33	33
2025	10	5	3	20	30	29.8	-3.4	1.182	0.5	0.4	0	43.9	37	0	136	118	0	34	32	33
2025	10	5	3	30	30	29	-2.9	1.182	0.4	0.3	0	44.3	37	0	137	119	0	34	33	33
2025	10	5	3	40	30	28.6	-2.2	1.182	0.4	0.3	0	44.7	37.8	0	137	120	0	33	32	33
2025	10	5	3	50	30	28.9	-3.9	1.182	0.3	0.2	0	44.3	37	0	137	119	0	34	33	34
2025	10	5	4	0	30	29.7	-3	1.182	0.3	0.2	0	44.7	37.4	0	137	119	0	33	32	33
2025	10	5	4	10	30	29.5	-2.4	1.182	0.3	0.2	0	44.3	37	0	137	119	0	34	33	33
2025	10	5	4	20	30	29.7	-2.6	1.182	0.3	0.2	0	44.7	37.4	0	137	119	0	33	32	34
2025	10	5	4	30	30	29.3	-2.9	1.182	0.4	0.3	0	44.7	37.4	0	137	119	0	33	32	33
2025	10	5	4	40	30	28.7	-2.4	1.182	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	5	4	50	30	29.7	-2.2	1.182	0.4	0.3	0	44.7	37.4	0	137	119	0	33	32	33
2025	10	5	5	0	30	29.5	-2.7	1.182	0.4	0.3	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	5	5	10	30	30	-3.4	1.182	0.3	0.2	0	43.9	37.4	0	136	119	0	34	32	33
2025	10	5	5	20	30	29.5	-1.9	1.182	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	5	5	30	30	30.2	-3.6	1.182	0.5	0.4	0	43.9	37.4	0	136	119	0	34	32	33
2025	10	5	5	40	30	29.9	-2.6	1.182	0.3	0.2	0	44.3	37	0	137	119	0	34	33	33
2025	10	5	5	50	30	29.4	-3.1	1.182	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	5	6	0	30	29.9	-3.8	1.182	0.3	0.2	0	44.7	37.4	0	137	119	0	33	32	33
2025	10	5	6	10	30	29.7	-2.1	1.182	0.6	0.5	0	44.7	37.4	0	137	119	0	33	32	33
2025	10	5	6	20	30	29.2	-2.1	1.182	0.3	0.2	0	44.3	37	0	136	119	0	33	33	33
2025	10	5	6	30	30	29.2	-2.8	1.182	0.3	0.2	0	44.3	37	0	137	119	0	34	33	33
2025	10	5	6	40	30	29	-3.9	1.182	0.5	0.4	0	43.9	36.5	0	136	118	0	34	33	33
2025	10	5	6	50	30	30.8	-3.4	1.182	0.4	0.3	0	44.3	37	0	136	118	0	33	32	33
2025	10	5	7	0	30	28.9	-2	1.182	0.3	0.2	0	43.9	36.1	0	135	117	0	33	33	33
2025	10	5	7	10	30	30.1	-2.9	1.182	0.3	0.2	0	43.4	36.5	0	134	117	0	33	32	33
2025	10	5	7	20	30	29.6	-3	1.182	0.3	0.2	0	43.4	35.7	0	134	116	0	33	33	34
2025	10	5	7	30	30	28.4	-1.7	1.182	0.4	0.3	0	43	35.7	0	134	116	0	34	33	34
2025	10	5	7	40	30	27.8	-2.2	1.182	0.4	0.3	0	42.6	36.1	0	133	116	0	34	32	33
2025	10	5	7	50	30	28	-2.1	1.182	0.3	0.2	0	43.4	36.1	0	134	116	0	33	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	5	8	0	30	28	-3.7	1.182	0.5	0.4	0	42.6	35.7	0	133	115	0	34	32	34
2025	10	5	8	10	30	27.8	-1.9	1.182	0.3	0.2	0	42.6	36.1	0	133	116	0	34	32	33
2025	10	5	8	20	30	29.2	-2.4	1.182	0.4	0.3	0	42.1	35.3	0	132	115	0	34	33	34
2025	10	5	8	30	30	28.3	-2.3	1.182	0.3	0.2	0	42.1	34.8	0	132	114	0	34	33	34
2025	10	5	8	40	30	28.7	-2.9	1.182	0.4	0.3	0	41.7	35.3	0	131	114	0	34	32	33
2025	10	5	8	50	30	30.7	-3.3	1.182	0.5	0.4	0	42.1	34.8	0	131	114	0	33	33	33
2025	10	5	9	0	30	29.2	-2.4	1.182	0.4	0.3	0	41.7	34.8	0	131	113	0	34	32	33
2025	10	5	9	10	30	28.8	-1.7	1.182	0.4	0.3	0	41.7	34.8	0	131	114	0	34	33	33
2025	10	5	9	20	30	29	-2.1	1.182	0.3	0.2	0	41.7	34.8	0	131	113	0	34	32	33
2025	10	5	9	30	30	31.1	-2.2	1.182	0.3	0.2	0	41.7	35.3	0	131	114	0	34	32	34
2025	10	5	9	40	30	30.2	-3.6	1.182	0.4	0.3	0	42.1	34.8	0	131	113	0	33	32	33
2025	10	5	9	50	30	28.4	-3	1.182	0.3	0.2	0	42.1	35.3	0	131	114	0	33	32	33
2025	10	5	10	0	30	29.7	-2.1	1.183	0.3	0.2	0	42.6	35.7	0	132	115	0	33	32	33
2025	10	5	10	10	30	29.6	-2.6	1.183	0.4	0.3	0	42.1	35.7	0	132	115	0	34	32	34
2025	10	5	10	20	30	28.6	-2.2	1.183	0.3	0.2	0	42.1	35.3	0	132	115	0	34	33	33
2025	10	5	10	30	30	30	-2.1	1.183	0.3	0.2	0	41.7	34.8	0	131	114	0	34	33	33
2025	10	5	10	40	30	28.9	-2.3	1.183	0.3	0.2	0	42.1	35.7	0	132	115	0	34	32	33
2025	10	5	10	50	30	28.8	-2.6	1.183	0.3	0.2	0	42.1	35.7	0	132	115	0	34	32	33
2025	10	5	11	0	30	28.7	-5	1.183	0.3	0.2	0	41.7	34.4	0	131	114	0	34	34	32
2025	10	5	11	10	30	29	-1.9	1.183	0.3	0.2	0	41.7	34.8	0	131	114	0	34	33	33
2025	10	5	11	20	30	29.4	-2.8	1.183	0.4	0.3	0	41.7	34.8	0	131	114	0	34	33	33
2025	10	5	11	30	30	28.8	-2.6	1.183	0.3	0.2	0	41.7	34.8	0	131	114	0	34	33	34
2025	10	5	11	40	30	28.8	-2.7	1.183	0.5	0.4	0	41.7	35.3	0	131	114	0	34	32	33
2025	10	5	11	50	30	30.1	-2.5	1.183	0.4	0.3	0	41.7	35.3	0	131	114	0	34	32	34
2025	10	5	12	0	30	29.7	-2.9	1.183	0.3	0.2	0	42.1	34.8	0	131	113	0	33	32	33
2025	10	5	12	10	30	29.3	-2.5	1.183	0.3	0.2	0	41.7	35.3	0	131	114	0	34	32	33
2025	10	5	12	20	30	27.9	-2.3	1.183	0.3	0.2	0	41.7	35.3	0	131	114	0	34	32	33
2025	10	5	12	30	30	29.9	-3.6	1.183	0.5	0.4	0	41.3	34.8	0	130	113	0	34	32	33
2025	10	5	12	40	30	29.5	-3.4	1.183	0.3	0.2	0	41.3	34.8	0	130	113	0	34	32	33
2025	10	5	12	50	30	29.9	-3.8	1.183	0.4	0.3	0	41.3	34.8	0	130	113	0	34	32	34
2025	10	5	13	0	30	30.6	-3.6	1.183	0.3	0.2	0	41.7	34.8	0	130	113	0	33	32	32
2025	10	5	13	10	30	29.1	-3.3	1.183	0.4	0.3	0	42.6	35.3	0	132	115	0	33	33	33
2025	10	5	13	20	30	29.5	-3.4	1.183	0.3	0.2	0	41.7	34.8	0	131	114	0	34	33	33
2025	10	5	13	30	30	30.6	-3.9	1.183	0.3	0.2	0	42.6	35.7	0	132	115	0	33	32	33
2025	10	5	13	40	30	29.2	-3	1.183	0.3	0.2	0	41.7	34.8	0	131	114	0	34	33	34
2025	10	5	13	50	30	29.8	-2.4	1.183	0.4	0.3	0	41.7	35.3	0	131	114	0	34	32	32
2025	10	5	14	0	30	29.9	-2.5	1.183	0.4	0.3	0	42.1	35.7	0	131	115	0	33	32	33
2025	10	5	14	10	30	28.5	-2.7	1.183	0.3	0.2	0	41.7	35.3	0	131	114	0	34	32	33
2025	10	5	14	20	30	30.2	-2.7	1.183	0.3	0.2	0	42.1	35.7	0	132	116	0	34	33	33
2025	10	5	14	30	30	29.6	-3.5	1.183	0.4	0.3	0	43	35.7	0	133	116	0	33	33	34
2025	10	5	14	40	30	29.8	-2.2	1.183	0.3	0.2	0	42.1	35.7	0	132	115	0	34	32	32
2025	10	5	14	50	30	30.2	-3.5	1.183	0.5	0.4	0	42.6	36.1	0	133	116	0	34	32	33
2025	10	5	15	0	30	29.3	-2.7	1.183	0.4	0.3	0	43.4	36.5	0	134	117	0	33	32	33
2025	10	5	15	10	30	28.6	-2.3	1.182	0.3	0.2	0	43	35.7	0	133	116	0	33	33	33
2025	10	5	15	20	30	30.2	-2.4	1.182	0.4	0.3	0	43	36.1	0	133	116	0	33	32	34
2025	10	5	15	30	30	29	-1.9	1.183	0.3	0.2	0	42.6	35.3	0	132	115	0	33	33	34
2025	10	5	15	40	30	29.2	-2.7	1.182	0.3	0.2	0	42.6	36.1	0	133	116	0	34	32	33
2025	10	5	15	50	30	29.3	-3	1.183	0.4	0.3	0	42.1	35.3	0	132	115	0	34	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	5	16	0	30	29.8	-2.9	1.182	0.4	0.3	0	42.1	35.7	0	132	115	0	34	32	34
2025	10	5	16	10	30	29.3	-2.4	1.183	0.3	0.2	0	42.1	35.3	0	132	115	0	34	33	32
2025	10	5	16	20	30	28.9	-2.7	1.182	0.5	0.4	0	42.6	36.1	0	133	116	0	34	32	33
2025	10	5	16	30	30	29.8	-1.7	1.183	0.3	0.2	0	42.6	35.7	0	132	115	0	33	32	33
2025	10	5	16	40	30	28.4	-2.5	1.182	0.4	0.3	0	42.1	35.3	0	131	115	0	33	33	33
2025	10	5	16	50	30	29.4	-3.1	1.182	0.4	0.3	0	43	35.7	0	133	115	0	33	32	33
2025	10	5	17	0	30	29.1	-2.8	1.182	0.4	0.3	0	43	35.7	0	133	115	0	33	32	34
2025	10	5	17	10	30	29.4	-3.5	1.182	0.3	0.2	0	43	35.3	0	133	115	0	33	33	33
2025	10	5	17	20	30	28.3	-3	1.182	0.3	0.2	0	42.1	35.7	0	132	115	0	34	32	33
2025	10	5	17	30	30	29.6	-2.7	1.182	0.3	0.2	0	42.6	35.7	0	133	115	0	34	32	33
2025	10	5	17	40	30	29.3	-2.4	1.182	0.3	0.2	0	42.6	35.7	0	133	116	0	34	33	33
2025	10	5	17	50	30	30.3	-3.2	1.183	0.4	0.3	0	43	36.1	0	133	116	0	33	32	34
2025	10	5	18	0	30	28.7	-3.5	1.182	0.3	0.2	0	42.6	35.7	0	133	115	0	34	32	33
2025	10	5	18	10	30	28.7	-4.4	1.182	0.3	0.2	0	42.6	35.7	0	133	115	0	34	32	33
2025	10	5	18	20	30	30	-3.7	1.182	0.5	0.4	0	42.6	36.1	0	133	116	0	34	32	34
2025	10	5	18	30	30	30.9	-4.2	1.182	0.3	0.2	0	43.4	36.1	0	134	116	0	33	32	33
2025	10	5	18	40	30	29.8	-3.9	1.182	0.3	0.2	0	43	36.1	0	134	116	0	34	32	33
2025	10	5	18	50	30	29.5	-3.7	1.182	0.3	0.2	0	43.4	37	0	135	118	0	34	32	33
2025	10	5	19	0	30	29.2	-2.7	1.182	0.3	0.2	0	43.9	36.5	0	136	118	0	34	33	33
2025	10	5	19	10	30	30.1	-3.2	1.182	0.3	0.2	0	43.9	36.5	0	136	118	0	34	33	33
2025	10	5	19	20	30	29.4	-2.3	1.182	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	5	19	30	30	29.4	-3.5	1.182	0.3	0.2	0	44.7	37.4	0	137	119	0	33	32	33
2025	10	5	19	40	30	29.5	-4.5	1.182	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	5	19	50	30	29.5	-2.6	1.182	0.4	0.3	0	44.7	37.4	0	137	120	0	33	33	33
2025	10	5	20	0	30	30.5	-2.8	1.182	0.4	0.3	0	44.3	37.8	0	137	120	0	34	32	33
2025	10	5	20	10	30	29.3	-3.2	1.182	0.4	0.3	0	44.3	37.4	0	137	120	0	34	33	33
2025	10	5	20	20	30	30.3	-2.7	1.182	0.3	0.2	0	44.3	37.8	0	137	120	0	34	32	33
2025	10	5	20	30	30	29.6	-2.4	1.182	0.3	0.2	0	44.7	37.8	0	137	120	0	33	32	33
2025	10	5	20	40	30	29.9	-3.3	1.182	0.3	0.2	0	44.3	37	0	137	120	0	34	34	33
2025	10	5	20	50	30	30.1	-2.2	1.182	0.3	0.2	0	44.7	37	0	138	120	0	34	34	33
2025	10	5	21	0	30	28.6	-3.1	1.182	0.3	0.2	0	44.3	37.4	0	137	120	0	34	33	34
2025	10	5	21	10	30	29.8	-2.4	1.182	0.3	0.2	0	44.3	37	0	137	119	0	34	33	33
2025	10	5	21	20	30	29.8	-3.2	1.182	0.4	0.3	0	44.7	37	0	137	119	0	33	33	33
2025	10	5	21	30	30	29.5	-3.4	1.182	0.3	0.2	0	44.7	37	0	137	119	0	33	33	33
2025	10	5	21	40	30	31.2	-2.9	1.183	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	5	21	50	30	29.3	-2.6	1.183	0.4	0.3	0	45.2	37.8	0	138	120	0	33	32	34
2025	10	5	22	0	30	31.2	-2.5	1.183	0.5	0.4	0	45.2	37.4	0	138	120	0	33	33	33
2025	10	5	22	10	30	30.7	-3.4	1.182	0.4	0.3	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	5	22	20	30	30.3	-3.4	1.183	0.5	0.4	0	45.2	37.8	0	138	120	0	33	32	33
2025	10	5	22	30	30	29.7	-2	1.183	0.3	0.2	0	44.3	37.4	0	137	120	0	34	33	34
2025	10	5	22	40	30	29.7	-2	1.183	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	5	22	50	30	30.3	-2.8	1.183	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	34
2025	10	5	23	0	30	29.9	-3.2	1.183	0.5	0.4	0	44.3	37.8	0	137	120	0	34	32	33
2025	10	5	23	10	30	30	-2.6	1.183	0.3	0.2	0	44.3	37.4	0	137	120	0	34	33	33
2025	10	5	23	20	30	29.6	-3.2	1.183	0.5	0.4	0	44.7	37.4	0	137	120	0	33	33	34
2025	10	5	23	30	30	29.1	-1.9	1.183	0.5	0.4	0	44.3	37.4	0	137	120	0	34	33	33
2025	10	5	23	40	30	30	-2.6	1.183	0.3	0.2	0	44.7	37.4	0	137	120	0	33	33	33
2025	10	5	23	50	30	29.4	-3.9	1.183	0.3	0.2	0	44.3	37.8	0	137	120	0	34	32	32

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	6	0	0	30	29.9	-2.4	1.183	0.3	0.2	0	44.3	37.4	0	137	120	0	34	33	34
2025	10	6	0	10	30	30.7	-2.8	1.183	0.3	0.2	0	44.7	37.8	0	137	120	0	33	32	33
2025	10	6	0	20	30	29.9	-2.6	1.183	0.3	0.2	0	44.3	37.4	0	137	120	0	34	33	33
2025	10	6	0	30	30	31	-3.6	1.183	0.5	0.4	0	44.3	38.3	0	137	120	0	34	31	33
2025	10	6	0	40	30	29.6	-3	1.183	0.5	0.4	0	44.7	37.8	0	137	120	0	33	32	33
2025	10	6	0	50	30	29.6	-2.9	1.183	0.4	0.3	0	44.3	37.8	0	137	120	0	34	32	33
2025	10	6	1	0	30	29	-2.8	1.183	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	6	1	10	30	29.1	-2.3	1.183	0.3	0.2	0	44.7	37.8	0	137	120	0	33	32	33
2025	10	6	1	20	30	29.3	-2.7	1.183	0.4	0.3	0	44.7	37.8	0	138	120	0	34	32	33
2025	10	6	1	30	30	28.8	-2.4	1.183	0.5	0.4	0	44.3	37.8	0	137	120	0	34	32	34
2025	10	6	1	40	30	30	-2.1	1.183	0.3	0.2	0	45.2	37.8	0	139	120	0	34	32	34
2025	10	6	1	50	30	28.3	-1.8	1.183	0.5	0.4	0	45.6	37.4	0	139	120	0	33	33	33
2025	10	6	2	0	30	30.2	-3.1	1.183	0.3	0.2	0	44.7	37.8	0	139	120	0	35	32	33
2025	10	6	2	10	30	30	-2.5	1.183	0.4	0.3	0	45.2	37	0	139	119	0	34	33	34
2025	10	6	2	20	30	28.3	-1.6	1.183	0.4	0.3	0	45.6	37.8	0	140	120	0	34	32	34
2025	10	6	2	30	30	28.2	-2.6	1.183	0.4	0.3	0	45.2	37.4	0	139	120	0	34	33	34
2025	10	6	2	40	30	29.5	-3	1.184	0.4	0.3	0	45.2	37	0	139	119	0	34	33	34
2025	10	6	2	50	30	29.4	-2.1	1.184	0.5	0.4	0	45.6	37.8	0	139	120	0	33	32	33
2025	10	6	3	0	30	29.7	-3.5	1.184	0.4	0.3	0	45.6	37.8	0	139	120	0	33	32	33
2025	10	6	3	10	30	29.8	-2.9	1.184	0.3	0.2	0	45.2	37.4	0	139	120	0	34	33	33
2025	10	6	3	20	30	30	-2.4	1.184	0.5	0.4	0	45.2	37.4	0	139	120	0	34	33	33
2025	10	6	3	30	30	29.2	-2.1	1.183	0.4	0.3	0	45.2	37.8	0	139	120	0	34	32	33
2025	10	6	3	40	30	29.7	-2.6	1.184	0.4	0.3	0	44.7	37	0	138	119	0	34	33	34
2025	10	6	3	50	30	28.5	-2.4	1.184	0.6	0.5	0	44.7	37.8	0	139	120	0	35	32	33
2025	10	6	4	0	30	30.4	-2.9	1.184	0.3	0.2	0	45.2	37.4	0	139	119	0	34	32	33
2025	10	6	4	10	30	29.2	-3.5	1.184	0.3	0.2	0	44.7	37.4	0	138	119	0	34	32	34
2025	10	6	4	20	30	29.7	-3.9	1.184	0.3	0.2	0	45.2	37.4	0	139	120	0	34	33	33
2025	10	6	4	30	30	30.3	-3.4	1.184	0.4	0.3	0	44.7	37	0	138	119	0	34	33	33
2025	10	6	4	40	30	29.2	-2.6	1.184	0.3	0.2	0	45.2	37.4	0	138	119	0	33	32	34
2025	10	6	4	50	30	27.7	-2.6	1.184	0.4	0.3	0	45.6	37.4	0	139	120	0	33	33	34
2025	10	6	5	0	30	29	-1.9	1.184	0.5	0.4	0	45.2	37.4	0	139	119	0	34	32	34
2025	10	6	5	10	30	29.5	-2.3	1.184	0.4	0.3	0	45.2	37	0	139	119	0	34	33	33
2025	10	6	5	20	30	29.4	-2.1	1.184	0.5	0.4	0	45.2	37.8	0	139	120	0	34	32	32
2025	10	6	5	30	30	29.6	-3	1.184	0.3	0.2	0	44.7	37	0	138	119	0	34	33	34
2025	10	6	5	40	30	28.9	-3.6	1.184	0.3	0.2	0	44.7	37	0	138	119	0	34	33	33
2025	10	6	5	50	30	29.9	-3	1.184	0.4	0.3	0	44.7	37.4	0	138	119	0	34	32	34
2025	10	6	6	0	30	29	-2.4	1.184	0.4	0.3	0	45.2	37	0	138	119	0	33	33	33
2025	10	6	6	10	30	30.8	-3.4	1.184	0.3	0.2	0	45.2	37	0	138	119	0	33	33	34
2025	10	6	6	20	30	30.3	-3	1.184	0.4	0.3	0	44.3	37	0	138	119	0	35	33	33
2025	10	6	6	30	30	29.4	-2.9	1.184	0.5	0.4	0	44.7	37	0	138	119	0	34	33	33
2025	10	6	6	40	30	29.4	-3.1	1.184	0.3	0.2	0	44.7	37.4	0	138	119	0	34	32	33
2025	10	6	6	50	30	29.6	-3.9	1.184	0.3	0.2	0	44.3	36.5	0	137	118	0	34	33	33
2025	10	6	7	0	30	28.9	-3.2	1.184	0.3	0.2	0	44.3	36.5	0	137	118	0	34	33	34
2025	10	6	7	10	30	30.1	-3.4	1.184	0.3	0.2	0	43.9	36.5	0	136	117	0	34	32	33
2025	10	6	7	20	30	29.8	-2.6	1.185	0.4	0.3	0	43.9	36.5	0	136	117	0	34	32	34
2025	10	6	7	30	30	29.8	-3.6	1.185	0.3	0.2	0	43.4	36.5	0	135	117	0	34	32	33
2025	10	6	7	40	30	29.4	-3	1.185	0.3	0.2	0	44.3	36.1	0	136	117	0	33	33	34
2025	10	6	7	50	30	29.4	-2.9	1.186	0.4	0.3	0	43.4	36.1	0	135	116	0	34	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	6	8	0	30	30.2	-3.6	1.186	0.3	0.2	0	43.4	36.5	0	135	117	0	34	32	33
2025	10	6	8	10	30	30.4	-3.4	1.186	0.3	0.2	0	43	35.7	0	134	116	0	34	33	33
2025	10	6	8	20	30	29.2	-2.3	1.186	0.4	0.3	0	43.4	35.7	0	134	116	0	33	33	33
2025	10	6	8	30	30	29.5	-2.8	1.186	0.4	0.3	0	43.4	35.3	0	134	115	0	33	33	33
2025	10	6	8	40	30	27.9	-1.7	1.187	0.3	0.2	0	43	36.1	0	134	116	0	34	32	34
2025	10	6	8	50	30	29.4	-2.5	1.187	0.4	0.3	0	43	36.1	0	134	116	0	34	32	33
2025	10	6	9	0	30	28.9	-3	1.187	0.4	0.3	0	42.6	35.7	0	133	115	0	34	32	33
2025	10	6	9	10	30	29.1	-2.7	1.187	0.4	0.3	0	42.6	35.3	0	133	115	0	34	33	34
2025	10	6	9	20	30	28.9	-2.3	1.188	0.5	0.4	0	42.6	34.8	0	133	114	0	34	33	33
2025	10	6	9	30	30	28.8	-1.6	1.187	0.3	0.2	0	42.6	35.7	0	133	115	0	34	32	34
2025	10	6	9	40	30	30.1	-2.9	1.188	0.5	0.4	0	42.6	35.3	0	133	114	0	34	32	34
2025	10	6	9	50	30	29.7	-2.6	1.188	0.3	0.2	0	42.6	35.3	0	133	115	0	34	33	34
2025	10	6	10	0	30	29.2	-3.1	1.187	0.4	0.3	0	42.6	35.7	0	133	115	0	34	32	34
2025	10	6	10	10	30	29.5	-3.1	1.189	0.4	0.3	0	43	36.1	0	134	116	0	34	32	34
2025	10	6	10	20	30	29.3	-3.4	1.189	0.3	0.2	0	43	35.7	0	133	116	0	33	33	34
2025	10	6	10	30	30	29.2	-3.9	1.188	0.3	0.2	0	42.6	35.7	0	133	115	0	34	32	34
2025	10	6	10	40	30	28.5	-2.6	1.188	0.3	0.2	0	42.6	35.3	0	133	115	0	34	33	33
2025	10	6	10	50	30	30.3	-2.8	1.188	0.4	0.3	0	42.6	35.3	0	133	115	0	34	33	34
2025	10	6	11	0	30	29.7	-3.3	1.188	0.4	0.3	0	43.4	36.1	0	135	117	0	34	33	33
2025	10	6	11	10	30	30.1	-2.6	1.188	0.5	0.4	0	43	36.1	0	134	117	0	34	33	34
2025	10	6	11	20	30	29.8	-2.7	1.187	0.4	0.3	0	43	36.1	0	134	117	0	34	33	33
2025	10	6	11	30	30	29.9	-3	1.187	0.4	0.3	0	42.6	35.7	0	133	116	0	34	33	33
2025	10	6	11	40	30	29.6	-2.6	1.187	0.4	0.3	0	43	36.1	0	134	116	0	34	32	33
2025	10	6	11	50	30	29.9	-3.1	1.188	0.4	0.3	0	43	36.1	0	134	116	0	34	32	34
2025	10	6	12	0	30	30.4	-3.2	1.187	0.4	0.3	0	42.6	36.1	0	133	116	0	34	32	33
2025	10	6	12	10	30	30.1	-3.4	1.187	0.4	0.3	0	42.6	35.7	0	133	116	0	34	33	33
2025	10	6	12	20	30	28.3	-3.2	1.187	0.5	0.4	0	43	35.7	0	134	116	0	34	33	33
2025	10	6	12	30	30	29.9	-2.6	1.187	0.3	0.2	0	43	36.1	0	133	116	0	33	32	34
2025	10	6	12	40	30	30.3	-3.2	1.187	0.3	0.2	0	43	35.3	0	133	115	0	33	33	35
2025	10	6	12	50	30	30	-2.9	1.187	0.4	0.3	0	43	35.7	0	133	116	0	33	33	33
2025	10	6	13	0	30	30.9	-3.2	1.187	0.3	0.2	0	43	35.7	0	133	115	0	33	32	33
2025	10	6	13	10	30	29.2	-2.8	1.187	0.4	0.3	0	43	35.7	0	134	116	0	34	33	34
2025	10	6	13	20	30	30.4	-4.1	1.186	0.4	0.3	0	43	35.3	0	133	115	0	33	33	34
2025	10	6	13	30	30	30	-3.5	1.186	0.3	0.2	0	42.6	35.3	0	133	115	0	34	33	34
2025	10	6	13	40	30	29.5	-3.2	1.186	0.3	0.2	0	42.1	35.7	0	133	116	0	35	33	34
2025	10	6	13	50	30	29.6	-1.7	1.186	0.3	0.2	0	42.6	36.1	0	133	116	0	34	32	33
2025	10	6	14	0	30	29.2	-3.8	1.186	0.3	0.2	0	43.4	36.1	0	135	117	0	34	33	33
2025	10	6	14	10	30	29.8	-2.9	1.186	0.4	0.3	0	42.6	35.7	0	133	116	0	34	33	34
2025	10	6	14	20	30	29.5	-3.4	1.186	0.3	0.2	0	42.6	36.1	0	133	116	0	34	32	34
2025	10	6	14	30	30	30.9	-3	1.186	0.3	0.2	0	42.6	36.1	0	133	116	0	34	32	33
2025	10	6	14	40	30	29.6	-4.2	1.186	0.3	0.2	0	43	35.7	0	133	115	0	33	32	33
2025	10	6	14	50	30	29.6	-3.2	1.186	0.3	0.2	0	42.6	35.3	0	133	115	0	34	33	33
2025	10	6	15	0	30	28.7	-2.7	1.185	0.4	0.3	0	43	36.1	0	134	117	0	34	33	33
2025	10	6	15	10	30	30.3	-3	1.185	0.3	0.2	0	43.4	37	0	134	117	0	33	31	34
2025	10	6	15	20	30	28.6	-2.2	1.185	0.3	0.2	0	43	36.1	0	134	117	0	34	33	34
2025	10	6	15	30	30	30.4	-3.3	1.185	0.4	0.3	0	43	36.1	0	134	117	0	34	33	33
2025	10	6	15	40	30	28.7	-2.3	1.185	0.4	0.3	0	43	36.5	0	134	116	0	34	31	33
2025	10	6	15	50	30	29.5	-3.4	1.185	0.3	0.2	0	43	36.5	0	134	117	0	34	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	6	16	0	30	28.8	-2.7	1.185	0.3	0.2	0	43	35.7	0	134	116	0	34	33	33
2025	10	6	16	10	30	29.6	-3.7	1.185	0.3	0.2	0	42.6	35.7	0	133	116	0	34	33	33
2025	10	6	16	20	30	28	-2.7	1.185	0.4	0.3	0	43	35.7	0	134	116	0	34	33	33
2025	10	6	16	30	30	30.8	-2.7	1.185	0.3	0.2	0	43	36.1	0	133	116	0	33	32	34
2025	10	6	16	40	30	30.4	-4.3	1.185	0.5	0.4	0	42.6	35.3	0	133	115	0	34	33	33
2025	10	6	16	50	30	29.9	-3.8	1.185	0.3	0.2	0	43	35.3	0	133	115	0	33	33	33
2025	10	6	17	0	30	29.5	-3.9	1.185	0.3	0.2	0	42.6	35.7	0	133	115	0	34	32	33
2025	10	6	17	10	30	31.1	-3.8	1.185	0.4	0.3	0	42.6	35.3	0	133	115	0	34	33	34
2025	10	6	17	20	30	29.9	-4	1.185	0.4	0.3	0	42.6	35.7	0	133	115	0	34	32	33
2025	10	6	17	30	30	29.4	-2.8	1.185	0.4	0.3	0	43	35.3	0	134	115	0	34	33	33
2025	10	6	17	40	30	29.9	-3.1	1.185	0.3	0.2	0	43	35.7	0	134	116	0	34	33	33
2025	10	6	17	50	30	29.5	-2.8	1.185	0.3	0.2	0	43	36.1	0	133	116	0	33	32	33
2025	10	6	18	0	30	30	-2.3	1.185	0.5	0.4	0	43.9	36.1	0	135	116	0	33	32	33
2025	10	6	18	10	30	29.8	-2.7	1.185	0.3	0.2	0	43.4	35.3	0	135	116	0	34	34	34
2025	10	6	18	20	30	28.2	-2.3	1.185	0.4	0.3	0	43.4	36.5	0	135	117	0	34	32	33
2025	10	6	18	30	30	28	-2.1	1.185	0.3	0.2	0	43.4	36.5	0	135	117	0	34	32	33
2025	10	6	18	40	30	29.6	-3.2	1.185	0.4	0.3	0	43.9	36.1	0	136	117	0	34	33	33
2025	10	6	18	50	30	29.9	-3	1.185	0.4	0.3	0	43.9	36.5	0	136	118	0	34	33	34
2025	10	6	19	0	30	30.4	-3.5	1.186	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	6	19	10	30	28.5	-2.6	1.186	0.3	0.2	0	45.2	37.4	0	138	119	0	33	32	33
2025	10	6	19	20	30	30.5	-3.4	1.186	0.4	0.3	0	44.7	37	0	137	119	0	33	33	33
2025	10	6	19	30	30	30.3	-3	1.186	0.3	0.2	0	44.7	37.8	0	138	120	0	34	32	33
2025	10	6	19	40	30	30.2	-2.8	1.186	0.3	0.2	0	45.2	37.4	0	138	120	0	33	33	33
2025	10	6	19	50	30	27.1	-2.5	1.186	0.3	0.2	0	45.2	38.3	0	139	121	0	34	32	33
2025	10	6	20	0	30	28.8	-4.5	1.186	0.3	0.2	0	45.2	37.4	0	138	120	0	33	33	33
2025	10	6	20	10	30	28.1	-2.5	1.187	0.4	0.3	0	45.2	37.8	0	139	121	0	34	33	33
2025	10	6	20	20	30	30.3	-2.8	1.186	0.4	0.3	0	44.7	37.8	0	138	120	0	34	32	33
2025	10	6	20	30	30	28.8	-2.9	1.187	0.3	0.2	0	45.6	37.8	0	139	121	0	33	33	33
2025	10	6	20	40	30	29.5	-1.5	1.187	0.5	0.4	0	45.2	38.3	0	139	121	0	34	32	34
2025	10	6	20	50	30	28.9	-2.3	1.188	0.4	0.3	0	45.2	37.8	0	139	120	0	34	32	34
2025	10	6	21	0	30	29.4	-3.4	1.187	0.3	0.2	0	45.2	38.3	0	139	121	0	34	32	34
2025	10	6	21	10	30	29.5	-2.5	1.188	0.3	0.2	0	45.2	37.8	0	139	120	0	34	32	34
2025	10	6	21	20	30	29.7	-2.6	1.188	0.4	0.3	0	44.7	37.8	0	138	121	0	34	33	33
2025	10	6	21	30	30	29.4	-2.1	1.189	0.3	0.2	0	44.7	37.8	0	139	121	0	35	33	34
2025	10	6	21	40	30	28.9	-3.2	1.189	0.3	0.2	0	45.6	37.8	0	139	121	0	33	33	33
2025	10	6	21	50	30	30.4	-2.1	1.189	0.3	0.2	0	45.6	37.8	0	139	121	0	33	33	33
2025	10	6	22	0	30	28.6	-1.6	1.189	0.4	0.3	0	46	38.3	0	140	121	0	33	32	34
2025	10	6	22	10	30	29.8	-2.7	1.189	0.4	0.3	0	45.2	37.4	0	139	120	0	34	33	34
2025	10	6	22	20	30	29.6	-2.9	1.189	0.5	0.4	0	45.2	37.8	0	139	121	0	34	33	34
2025	10	6	22	30	30	29.9	-3.2	1.189	0.5	0.4	0	45.2	37.8	0	139	120	0	34	32	33
2025	10	6	22	40	30	29.9	-3	1.189	0.3	0.2	0	45.2	37.8	0	139	120	0	34	32	33
2025	10	6	22	50	30	29.3	-3	1.189	0.3	0.2	0	45.2	38.3	0	139	121	0	34	32	33
2025	10	6	23	0	30	29.9	-3.2	1.189	0.4	0.3	0	45.2	37.8	0	139	120	0	34	32	33
2025	10	6	23	10	30	30.2	-2.9	1.189	0.5	0.4	0	44.7	37.4	0	138	120	0	34	33	34
2025	10	6	23	20	30	29.7	-3.2	1.189	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	6	23	30	30	29.7	-2.1	1.189	0.5	0.4	0	45.2	37.4	0	139	120	0	34	33	34
2025	10	6	23	40	30	29.4	-2.3	1.189	0.4	0.3	0	45.2	38.3	0	139	121	0	34	32	33
2025	10	6	23	50	30	28.8	-2.4	1.189	0.5	0.4	0	45.2	38.3	0	139	121	0	34	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	7	0	0	30	30.7	-2.4	1.189	0.5	0.4	0	45.2	37.8	0	138	120	0	33	32	33
2025	10	7	0	10	30	29.8	-3	1.189	0.4	0.3	0	44.7	37.4	0	138	120	0	34	33	34
2025	10	7	0	20	30	29	-2.6	1.189	0.4	0.3	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	7	0	30	30	29.9	-1.1	1.19	0.5	0.4	0	45.2	37	0	138	119	0	33	33	33
2025	10	7	0	40	30	28.9	-1.4	1.19	0.3	0.2	0	45.2	37.4	0	138	120	0	33	33	34
2025	10	7	0	50	30	30.1	-2.7	1.19	0.5	0.5	0	44.7	37.8	0	137	120	0	33	32	33
2025	10	7	1	0	30	29.1	-3	1.19	0.4	0.3	0	44.3	37.4	0	137	120	0	34	33	33
2025	10	7	1	10	30	30.2	-2.6	1.19	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	34
2025	10	7	1	20	30	28.5	-2.4	1.19	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	7	1	30	30	28.7	-3	1.19	0.3	0.2	0	44.3	37.4	0	137	120	0	34	33	34
2025	10	7	1	40	30	28.1	-2.2	1.19	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	7	1	50	30	29.4	-1.7	1.19	0.5	0.5	0	44.3	37.8	0	138	121	0	35	33	34
2025	10	7	2	0	30	29.4	-2.2	1.19	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	7	2	10	30	30.2	-4	1.19	0.5	0.4	0	44.3	37.4	0	137	119	0	34	32	34
2025	10	7	2	20	30	29.8	-2.6	1.19	0.4	0.3	0	45.2	37.8	0	138	120	0	33	32	34
2025	10	7	2	30	30	28.1	-2.7	1.19	0.3	0.2	0	44.7	37.4	0	137	120	0	33	33	34
2025	10	7	2	40	30	27.8	-2.6	1.19	0.4	0.3	0	45.2	37.8	0	139	121	0	34	33	34
2025	10	7	2	50	30	29.1	-2.9	1.19	0.4	0.3	0	44.3	37.4	0	137	120	0	34	33	33
2025	10	7	3	0	30	30.6	-2.1	1.19	0.4	0.3	0	44.3	37.4	0	137	120	0	34	33	33
2025	10	7	3	10	30	30.2	-3	1.19	0.3	0.2	0	44.7	37	0	137	119	0	33	33	34
2025	10	7	3	20	30	30.3	-2.6	1.19	0.3	0.2	0	44.3	37.4	0	137	120	0	34	33	33
2025	10	7	3	30	30	28.2	-3.5	1.19	0.4	0.3	0	44.3	37.4	0	137	119	0	34	32	34
2025	10	7	3	40	30	30.2	-2.5	1.191	0.4	0.3	0	44.3	37.4	0	137	120	0	34	33	33
2025	10	7	3	50	30	30.1	-2.9	1.19	0.4	0.3	0	44.7	37.4	0	137	119	0	33	32	34
2025	10	7	4	0	30	30.5	-3	1.19	0.4	0.3	0	44.7	37	0	137	119	0	33	33	34
2025	10	7	4	10	30	30.8	-3.4	1.191	0.4	0.3	0	43.9	37	0	136	119	0	34	33	33
2025	10	7	4	20	30	29.3	-3.3	1.191	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	34
2025	10	7	4	30	30	29.3	-2.7	1.191	0.3	0.2	0	44.3	37	0	137	119	0	34	33	34
2025	10	7	4	40	30	28.9	-3.4	1.191	0.3	0.2	0	43.9	37	0	136	119	0	34	33	33
2025	10	7	4	50	30	29.4	-2.3	1.191	0.4	0.3	0	44.3	37.4	0	137	120	0	34	33	34
2025	10	7	5	0	30	29	-2.8	1.191	0.3	0.2	0	43	37.4	0	134	119	0	34	32	33
2025	10	7	5	10	30	30	-3.4	1.191	0.5	0.4	0	43.9	37	0	136	119	0	34	33	33
2025	10	7	5	20	30	30.2	-3.4	1.191	0.4	0.3	0	44.3	36.5	0	137	119	0	34	34	33
2025	10	7	5	30	30	29.1	-1.6	1.191	0.4	0.3	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	7	5	40	30	29.4	-2.4	1.191	0.3	0.2	0	44.7	37.4	0	137	120	0	33	33	33
2025	10	7	5	50	30	29.1	-1.9	1.191	0.3	0.2	0	43.9	37.4	0	136	119	0	34	32	33
2025	10	7	6	0	30	29.8	-2.9	1.191	0.3	0.2	0	43.9	37	0	136	119	0	34	33	33
2025	10	7	6	10	30	29	-3	1.191	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	34
2025	10	7	6	20	30	29.2	-3	1.191	0.5	0.4	0	43.9	36.5	0	136	118	0	34	33	34
2025	10	7	6	30	30	29.6	-2.4	1.191	0.4	0.3	0	43.9	37	0	136	119	0	34	33	34
2025	10	7	6	40	30	30.6	-2.5	1.191	0.3	0.2	0	43.4	36.5	0	135	118	0	34	33	34
2025	10	7	6	50	30	30.2	-2.1	1.191	0.4	0.3	0	43.4	36.5	0	135	118	0	34	33	33
2025	10	7	7	0	30	28.9	-2.2	1.191	0.3	0.2	0	43.4	36.5	0	135	118	0	34	33	33
2025	10	7	7	10	30	29.6	-2.6	1.191	0.3	0.2	0	43	36.1	0	134	117	0	34	33	33
2025	10	7	7	20	30	29.6	-3	1.191	0.3	0.2	0	42.6	36.1	0	133	117	0	34	33	33
2025	10	7	7	30	30	28.9	-2.1	1.192	0.3	0.2	0	43	35.7	0	134	116	0	34	33	34
2025	10	7	7	40	30	30.4	-3.5	1.191	0.3	0.2	0	42.6	36.1	0	133	116	0	34	32	33
2025	10	7	7	50	30	29.3	-2.4	1.191	0.3	0.2	0	42.6	35.7	0	133	116	0	34	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	7	8	0	30	30.2	-2.5	1.191	0.3	0.2	0	42.6	35.7	0	133	116	0	34	33	34
2025	10	7	8	10	30	29.9	-2.7	1.191	0.4	0.3	0	42.6	35.7	0	132	116	0	33	33	33
2025	10	7	8	20	30	29.4	-2.2	1.192	0.4	0.3	0	42.1	35.7	0	132	116	0	34	33	33
2025	10	7	8	30	30	29.4	-3.4	1.192	0.3	0.2	0	42.1	35.3	0	132	115	0	34	33	34
2025	10	7	8	40	30	29.3	-2.6	1.192	0.3	0.2	0	42.1	35.3	0	132	115	0	34	33	34
2025	10	7	8	50	30	29.2	-2.9	1.192	0.5	0.4	0	42.1	35.7	0	132	115	0	34	32	34
2025	10	7	9	0	30	30	-3	1.192	0.5	0.4	0	42.1	35.3	0	131	114	0	33	32	33
2025	10	7	9	10	30	29.2	-2.6	1.192	0.3	0.2	0	42.1	35.3	0	131	115	0	33	33	33
2025	10	7	9	20	30	28.3	-2.1	1.192	0.3	0.2	0	41.7	35.7	0	131	115	0	34	32	34
2025	10	7	9	30	30	29.3	-2.8	1.192	0.3	0.2	0	42.1	35.3	0	132	115	0	34	33	34
2025	10	7	9	40	30	28.4	-2.6	1.192	0.3	0.2	0	42.1	35.7	0	132	116	0	34	33	33
2025	10	7	9	50	30	29.7	-2	1.192	0.3	0.2	0	42.6	36.1	0	133	116	0	34	32	33
2025	10	7	10	0	30	28.4	-3.6	1.192	0.5	0.5	0	42.1	35.7	0	132	116	0	34	33	34
2025	10	7	10	10	30	29.1	-3	1.192	0.5	0.4	0	41.7	35.7	0	132	116	0	35	33	33
2025	10	7	10	20	30	29.4	-3	1.193	0.4	0.3	0	42.1	35.7	0	132	116	0	34	33	34
2025	10	7	10	30	30	29.7	-1.8	1.193	0.4	0.3	0	42.1	36.1	0	132	116	0	34	32	34
2025	10	7	10	40	30	30.5	-2.8	1.193	0.4	0.3	0	42.1	35.7	0	132	116	0	34	33	33
2025	10	7	10	50	30	28.4	-3	1.193	0.4	0.3	0	41.7	35.7	0	132	116	0	35	33	33
2025	10	7	11	0	30	29.8	-2.2	1.193	0.4	0.3	0	42.1	36.1	0	132	116	0	34	32	34
2025	10	7	11	10	30	30.3	-2.6	1.193	0.4	0.3	0	42.1	36.1	0	132	116	0	34	32	33
2025	10	7	11	20	30	29.7	-3.3	1.193	0.4	0.3	0	42.1	35.7	0	132	116	0	34	33	34
2025	10	7	11	30	30	29.1	-2.4	1.193	0.3	0.2	0	41.7	35.7	0	131	116	0	34	33	33
2025	10	7	11	40	30	29.6	-3.2	1.193	0.5	0.4	0	42.1	35.7	0	131	115	0	33	32	34
2025	10	7	11	50	30	28.9	-2.8	1.193	0.5	0.4	0	41.7	35.7	0	131	115	0	34	32	33
2025	10	7	12	0	30	30	-3.3	1.193	0.3	0.2	0	42.1	35.3	0	131	115	0	33	33	34
2025	10	7	12	10	30	29.4	-3.5	1.193	0.3	0.2	0	42.1	35.7	0	132	116	0	34	33	33
2025	10	7	12	20	30	29.8	-4	1.193	0.4	0.3	0	42.1	35.7	0	132	116	0	34	33	33
2025	10	7	12	30	30	29.4	-3.4	1.193	0.5	0.4	0	42.1	35.7	0	132	116	0	34	33	33
2025	10	7	12	40	30	29.7	-3.3	1.193	0.3	0.2	0	42.1	36.1	0	132	116	0	34	32	34
2025	10	7	12	50	30	30.7	-2.6	1.193	0.4	0.3	0	41.7	35.7	0	131	115	0	34	32	34
2025	10	7	13	0	30	30.3	-3.4	1.193	0.4	0.3	0	41.7	35.7	0	131	115	0	34	32	33
2025	10	7	13	10	30	29.3	-4.3	1.193	0.3	0.2	0	41.7	34.8	0	131	115	0	34	34	33
2025	10	7	13	20	30	28.4	-3	1.193	0.5	0.4	0	41.7	34.8	0	131	115	0	34	34	33
2025	10	7	13	30	30	29	-2.8	1.193	0.5	0.4	0	41.7	35.7	0	131	115	0	34	32	34
2025	10	7	13	40	30	29.2	-3.3	1.193	0.4	0.3	0	41.7	35.7	0	131	115	0	34	32	33
2025	10	7	13	50	30	29.1	-2.9	1.193	0.3	0.2	0	42.1	35.3	0	131	115	0	33	33	33
2025	10	7	14	0	30	29.8	-2.2	1.193	0.3	0.2	0	42.1	35.3	0	131	115	0	33	33	34
2025	10	7	14	10	30	29.4	-4.2	1.193	0.3	0.2	0	42.1	35.7	0	132	116	0	34	33	34
2025	10	7	14	20	30	29.3	-3.7	1.193	0.3	0.2	0	42.1	36.5	0	133	117	0	35	32	33
2025	10	7	14	30	30	29.4	-4	1.193	0.4	0.3	0	42.1	35.7	0	132	116	0	34	33	34
2025	10	7	14	40	30	29.5	-1.3	1.193	0.5	0.5	0	42.6	36.5	0	133	117	0	34	32	34
2025	10	7	14	50	30	28.4	-2.3	1.193	0.4	0.3	0	43	37	0	134	118	0	34	32	33
2025	10	7	15	0	30	29.5	-3.1	1.193	0.4	0.3	0	42.6	36.5	0	134	117	0	35	32	33
2025	10	7	15	10	30	29.8	-3.2	1.193	0.4	0.3	0	42.6	36.1	0	133	117	0	34	33	33
2025	10	7	15	20	30	29.7	-2.3	1.193	0.4	0.3	0	43.4	37.4	0	135	119	0	34	32	34
2025	10	7	15	30	30	29.5	-2.3	1.193	0.4	0.3	0	44.3	37.4	0	136	119	0	33	32	34
2025	10	7	15	40	30	29.3	-3.5	1.193	0.3	0.2	0	42.6	36.5	0	133	117	0	34	32	33
2025	10	7	15	50	30	30.1	-2.2	1.193	0.3	0.2	0	42.1	36.1	0	133	117	0	35	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	7	16	0	30	28.3	-3.4	1.193	0.4	0.3	0	42.6	36.1	0	133	117	0	34	33	34
2025	10	7	16	10	30	29.4	-3	1.193	0.4	0.3	0	42.6	36.1	0	133	117	0	34	33	34
2025	10	7	16	20	30	29.3	-2.6	1.193	0.3	0.2	0	42.6	36.5	0	133	117	0	34	32	34
2025	10	7	16	30	30	29.3	-2.9	1.193	0.4	0.3	0	43	36.5	0	134	117	0	34	32	33
2025	10	7	16	40	30	29.6	-2.9	1.194	0.4	0.3	0	43	36.1	0	133	116	0	33	32	33
2025	10	7	16	50	30	30	-3	1.193	0.3	0.2	0	42.1	36.1	0	132	116	0	34	32	34
2025	10	7	17	0	30	29.5	-3.3	1.193	0.3	0.2	0	42.1	35.7	0	132	115	0	34	32	34
2025	10	7	17	10	30	29.5	-3.8	1.193	0.4	0.3	0	41.7	34.8	0	131	114	0	34	33	34
2025	10	7	17	20	30	30	-2.3	1.193	0.4	0.3	0	41.7	35.3	0	131	114	0	34	32	34
2025	10	7	17	30	30	30.3	-3.6	1.193	0.4	0.3	0	42.1	35.3	0	132	115	0	34	33	33
2025	10	7	17	40	30	29.4	-2.6	1.193	0.3	0.2	0	42.6	35.3	0	133	115	0	34	33	33
2025	10	7	17	50	30	31.8	-2.6	1.193	0.3	0.2	0	43	35.7	0	134	116	0	34	33	33
2025	10	7	18	0	30	29.8	-2.7	1.194	0.4	0.3	0	42.1	34.8	0	132	114	0	34	33	33
2025	10	7	18	10	30	29.7	-3.1	1.194	0.4	0.3	0	42.6	36.1	0	133	116	0	34	32	33
2025	10	7	18	20	30	29.7	-3.1	1.194	0.3	0.2	0	42.1	35.3	0	132	115	0	34	33	34
2025	10	7	18	30	30	31	-3.3	1.193	0.3	0.2	0	43	35.7	0	133	116	0	33	33	34
2025	10	7	18	40	30	29.9	-2.9	1.194	0.4	0.3	0	43.9	36.5	0	135	117	0	33	32	33
2025	10	7	18	50	30	29.3	-3	1.194	0.4	0.3	0	43.4	36.1	0	135	117	0	34	33	34
2025	10	7	19	0	30	29.4	-2.9	1.194	0.4	0.3	0	43.9	36.5	0	136	118	0	34	33	34
2025	10	7	19	10	30	29.9	-2.9	1.194	0.4	0.3	0	43.4	37.4	0	136	119	0	35	32	34
2025	10	7	19	20	30	29.4	-2.4	1.194	0.4	0.3	0	44.3	37	0	137	119	0	34	33	34
2025	10	7	19	30	30	30.6	-2.7	1.194	0.3	0.2	0	44.3	37	0	137	119	0	34	33	33
2025	10	7	19	40	30	29.1	-3	1.194	0.3	0.2	0	44.3	37.4	0	137	120	0	34	33	34
2025	10	7	19	50	30	30.3	-2.3	1.194	0.3	0.2	0	44.3	37	0	137	119	0	34	33	34
2025	10	7	20	0	30	30.3	-2.1	1.194	0.4	0.3	0	44.3	37	0	137	119	0	34	33	34
2025	10	7	20	10	30	30.1	-3.3	1.194	0.4	0.3	0	44.3	37	0	137	119	0	34	33	34
2025	10	7	20	20	30	30.1	-3.1	1.194	0.5	0.4	0	44.3	37.4	0	137	120	0	34	33	33
2025	10	7	20	30	30	29.4	-2.4	1.194	0.4	0.3	0	44.7	37.4	0	138	120	0	34	33	34
2025	10	7	20	40	30	30.8	-2.6	1.194	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	7	20	50	30	29.3	-3.1	1.194	0.5	0.5	0	44.3	37.8	0	137	120	0	34	32	34
2025	10	7	21	0	30	31	-4.3	1.194	0.4	0.3	0	44.3	37.4	0	137	120	0	34	33	33
2025	10	7	21	10	30	29.7	-2.5	1.194	0.4	0.3	0	44.3	37.8	0	137	120	0	34	32	33
2025	10	7	21	20	30	29.2	-2.9	1.194	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	7	21	30	30	30.2	-2.5	1.194	0.4	0.3	0	44.7	37.4	0	137	120	0	33	33	33
2025	10	7	21	40	30	30	-2.3	1.194	0.3	0.2	0	44.3	37.4	0	137	120	0	34	33	34
2025	10	7	21	50	30	29.6	-2.7	1.194	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	7	22	0	30	30.1	-2	1.194	0.4	0.3	0	44.3	37.4	0	137	120	0	34	33	34
2025	10	7	22	10	30	30.6	-2.6	1.194	0.4	0.3	0	44.7	37.4	0	137	119	0	33	32	33
2025	10	7	22	20	30	29.8	-3.4	1.195	0.3	0.2	0	43.9	37	0	136	119	0	34	33	33
2025	10	7	22	30	30	29.9	-2.6	1.194	0.3	0.2	0	44.3	37.4	0	137	120	0	34	33	34
2025	10	7	22	40	30	30.1	-2.1	1.195	0.5	0.4	0	43.9	37.4	0	136	119	0	34	32	33
2025	10	7	22	50	30	29.9	-2.6	1.195	0.4	0.3	0	43.9	37.4	0	136	119	0	34	32	34
2025	10	7	23	0	30	30.1	-2.6	1.195	0.3	0.2	0	43.9	37	0	136	119	0	34	33	33
2025	10	7	23	10	30	30.6	-2.1	1.195	0.3	0.2	0	43.4	37	0	136	119	0	35	33	34
2025	10	7	23	20	30	29	-2.3	1.195	0.3	0.2	0	43.9	37	0	136	119	0	34	33	34
2025	10	7	23	30	30	29.1	-2.7	1.195	0.3	0.2	0	43.9	36.5	0	136	119	0	34	34	33
2025	10	7	23	40	30	30.2	-2.4	1.195	0.3	0.2	0	44.3	37	0	136	119	0	33	33	34
2025	10	7	23	50	30	30.2	-3	1.195	0.4	0.3	0	43.4	36.5	0	135	118	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	8	0	0	30	31	-3.8	1.195	0.4	0.3	0	43.4	37.4	0	135	119	0	34	32	33
2025	10	8	0	10	30	30.4	-2.2	1.196	0.3	0.2	0	43.4	37	0	135	118	0	34	32	34
2025	10	8	0	20	30	30.1	-2.3	1.196	0.4	0.3	0	43.9	36.5	0	136	118	0	34	33	34
2025	10	8	0	30	30	29.3	-2.5	1.197	0.4	0.3	0	43.9	36.5	0	136	118	0	34	33	34
2025	10	8	0	40	30	28.7	-3.4	1.197	0.4	0.3	0	43.9	37	0	136	119	0	34	33	34
2025	10	8	0	50	30	29.2	-2.6	1.196	0.3	0.2	0	43.9	37	0	136	119	0	34	33	34
2025	10	8	1	0	30	29.9	-3.4	1.196	0.3	0.2	0	43.4	37	0	135	119	0	34	33	34
2025	10	8	1	10	30	29.6	-3.4	1.197	0.3	0.2	0	43.4	37.4	0	135	119	0	34	32	34
2025	10	8	1	20	30	30	-3	1.198	0.3	0.2	0	43.9	37	0	136	119	0	34	33	34
2025	10	8	1	30	30	28.8	-2.3	1.197	0.3	0.2	0	43.9	37.4	0	136	119	0	34	32	34
2025	10	8	1	40	30	30.8	-2.6	1.197	0.5	0.4	0	43.9	36.5	0	136	119	0	34	34	34
2025	10	8	1	50	30	29.2	-3	1.198	0.4	0.3	0	43.4	37	0	135	118	0	34	32	33
2025	10	8	2	0	30	29.2	-2.5	1.198	0.3	0.2	0	43.9	37	0	136	119	0	34	33	34
2025	10	8	2	10	30	30.5	-2.7	1.198	0.4	0.3	0	43.4	36.5	0	135	118	0	34	33	33
2025	10	8	2	20	30	29.2	-2.8	1.198	0.3	0.2	0	43.4	36.5	0	135	118	0	34	33	34
2025	10	8	2	30	30	30.8	-3.4	1.199	0.4	0.3	0	43.4	36.5	0	135	118	0	34	33	33
2025	10	8	2	40	30	30	-2.9	1.198	0.3	0.2	0	43.4	37	0	135	118	0	34	32	34
2025	10	8	2	50	30	30.1	-2.4	1.199	0.5	0.5	0	43.4	36.5	0	135	118	0	34	33	33
2025	10	8	3	0	30	29	-2.5	1.198	0.3	0.2	0	43.4	37	0	135	118	0	34	32	34
2025	10	8	3	10	30	31.3	-2.7	1.198	0.4	0.3	0	43.4	36.1	0	135	118	0	34	34	34
2025	10	8	3	20	30	29	-2.5	1.198	0.3	0.2	0	43.4	36.5	0	135	118	0	34	33	33
2025	10	8	3	30	30	28.9	-3	1.199	0.3	0.2	0	43.9	37.4	0	136	119	0	34	32	34
2025	10	8	3	40	30	29.7	-2.7	1.199	0.4	0.3	0	43.4	37	0	135	118	0	34	32	34
2025	10	8	3	50	30	30.4	-1.7	1.199	0.3	0.2	0	43.4	36.5	0	135	118	0	34	33	34
2025	10	8	4	0	30	28.8	-2.3	1.199	0.3	0.2	0	43.4	37	0	135	118	0	34	32	33
2025	10	8	4	10	30	27.7	-0.7	1.199	0.3	0.2	0	43.4	35.7	0	135	115	0	34	32	34
2025	10	8	4	20	30	29.9	-2.4	1.199	0.5	0.5	0	43.4	36.5	0	135	118	0	34	33	33
2025	10	8	4	30	30	28.5	-2.2	1.199	0.4	0.3	0	43.9	37	0	136	119	0	34	33	33
2025	10	8	4	40	30	30.5	-2.2	1.199	0.4	0.3	0	44.3	37.4	0	136	119	0	33	32	34
2025	10	8	4	50	30	29.9	-2.7	1.199	0.3	0.2	0	43.4	37	0	135	118	0	34	32	33
2025	10	8	5	0	30	29.9	-3.4	1.199	0.3	0.2	0	43.4	36.5	0	135	118	0	34	33	34
2025	10	8	5	10	30	29.6	-2.2	1.199	0.4	0.3	0	43.4	36.5	0	135	118	0	34	33	34
2025	10	8	5	20	30	30.1	-3.1	1.199	0.3	0.2	0	43.4	37	0	135	118	0	34	32	34
2025	10	8	5	30	30	29.3	-1.2	1.2	0.3	0.2	0	43.9	36.5	0	135	118	0	33	33	34
2025	10	8	5	40	30	30.4	-3.4	1.2	0.4	0.3	0	43.4	36.5	0	135	118	0	34	33	33
2025	10	8	5	50	30	29.8	-2.8	1.2	0.4	0.3	0	43.4	37	0	135	118	0	34	32	34
2025	10	8	6	0	30	29.8	-2.3	1.2	0.3	0.2	0	43	36.1	0	134	118	0	34	34	34
2025	10	8	6	10	30	28.9	-1.9	1.2	0.3	0.2	0	43.4	36.5	0	135	118	0	34	33	34
2025	10	8	6	20	30	30.9	-2	1.2	0.3	0.2	0	43	36.1	0	134	117	0	34	33	33
2025	10	8	6	30	30	29.8	-2.8	1.2	0.3	0.2	0	43	36.1	0	134	117	0	34	33	33
2025	10	8	6	40	30	29.8	-2.3	1.2	0.3	0.2	0	43	36.1	0	134	117	0	34	33	34
2025	10	8	6	50	30	29.4	-2.9	1.2	0.3	0.2	0	43	36.1	0	134	117	0	34	33	34
2025	10	8	7	0	30	29.4	-2.7	1.2	0.3	0.2	0	42.1	36.1	0	133	116	0	35	32	33
2025	10	8	7	10	30	30.4	-3.5	1.2	0.5	0.4	0	42.6	36.1	0	133	116	0	34	32	33
2025	10	8	7	20	30	30.1	-3.6	1.2	0.4	0.3	0	42.1	35.3	0	132	115	0	34	33	34
2025	10	8	7	30	30	29.5	-2.6	1.2	0.3	0.2	0	42.1	35.3	0	132	115	0	34	33	34
2025	10	8	7	40	30	29.4	-3	1.2	0.4	0.3	0	42.1	35.3	0	132	115	0	34	33	34
2025	10	8	7	50	30	28.9	-1.9	1.2	0.4	0.3	0	41.3	35.3	0	131	115	0	35	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	8	8	0	30	29.9	-3.4	1.2	0.4	0.3	0	41.7	35.3	0	131	115	0	34	33	34
2025	10	8	8	10	30	30	-2.1	1.201	0.3	0.2	0	42.1	35.3	0	131	115	0	33	33	33
2025	10	8	8	20	30	28.7	-1.7	1.201	0.4	0.3	0	42.1	35.3	0	131	115	0	33	33	34
2025	10	8	8	30	30	30.2	-2.2	1.201	0.4	0.3	0	41.3	35.3	0	130	114	0	34	32	34
2025	10	8	8	40	30	28.8	-0.8	1.201	0.3	0.2	0	41.7	35.3	0	131	114	0	34	32	33
2025	10	8	8	50	30	30.4	-2.7	1.201	0.3	0.2	0	40.4	34.4	0	129	113	0	35	33	33
2025	10	8	9	0	30	29.2	-2.5	1.201	0.3	0.2	0	40.9	34	0	129	112	0	34	33	33
2025	10	8	9	10	30	29.2	-2.1	1.202	0.4	0.3	0	40.4	33.5	0	128	112	0	34	34	33
2025	10	8	9	20	30	30.6	-3.1	1.201	0.3	0.2	0	41.3	35.3	0	130	114	0	34	32	34
2025	10	8	9	30	30	29.8	-1.8	1.202	0.4	0.3	0	41.7	35.3	0	131	115	0	34	33	33
2025	10	8	9	40	30	30.8	-2.8	1.201	0.3	0.2	0	40.9	35.3	0	130	114	0	35	32	33
2025	10	8	9	50	30	30.4	-2.1	1.202	0.3	0.2	0	41.7	35.7	0	131	115	0	34	32	33
2025	10	8	10	0	30	28.3	-2.8	1.202	0.3	0.2	0	42.1	35.3	0	131	114	0	33	32	34
2025	10	8	10	10	30	30.4	-3.5	1.202	0.4	0.3	0	41.7	35.3	0	131	115	0	34	33	34
2025	10	8	10	20	30	29	-3.1	1.202	0.4	0.3	0	41.3	35.3	0	130	115	0	34	33	34
2025	10	8	10	30	30	30.1	-2.8	1.202	0.3	0.2	0	41.3	34.8	0	130	114	0	34	33	34
2025	10	8	10	40	30	29.8	-3.6	1.202	0.4	0.3	0	40.9	34.4	0	129	113	0	34	33	34
2025	10	8	10	50	30	29.7	-3.4	1.202	0.3	0.2	0	41.7	35.7	0	131	115	0	34	32	34
2025	10	8	11	0	30	29.7	-2.6	1.202	0.4	0.3	0	41.7	35.3	0	131	115	0	34	33	34
2025	10	8	11	10	30	30.6	-3.9	1.202	0.5	0.4	0	40.9	34.8	0	129	114	0	34	33	33
2025	10	8	11	20	30	28.4	-3.5	1.202	0.4	0.3	0	41.3	34.8	0	130	114	0	34	33	34
2025	10	8	11	30	30	29.9	-4	1.202	0.3	0.2	0	41.3	34.4	0	129	113	0	33	33	34
2025	10	8	11	40	30	29.1	-2.9	1.202	0.4	0.3	0	41.3	35.3	0	130	114	0	34	32	33
2025	10	8	11	50	30	30.3	-3.1	1.202	0.4	0.3	0	40.9	34	0	129	113	0	34	34	33
2025	10	8	12	0	30	30.6	-2.5	1.202	0.3	0.2	0	40.9	34.8	0	129	113	0	34	32	34
2025	10	8	12	10	30	29.7	-2.4	1.202	0.3	0.2	0	41.7	34.8	0	130	114	0	33	33	33
2025	10	8	12	20	30	29.2	-4	1.201	0.3	0.2	0	40.9	34.4	0	129	113	0	34	33	34
2025	10	8	12	30	30	28.4	-2.2	1.201	0.3	0.2	0	40.9	34.8	0	129	113	0	34	32	33
2025	10	8	12	40	30	29.5	-2.8	1.201	0.3	0.2	0	41.3	34.8	0	130	114	0	34	33	34
2025	10	8	12	50	30	28.5	-2.2	1.199	0.3	0.2	0	42.1	35.7	0	131	115	0	33	32	34
2025	10	8	13	0	30	29.1	-2.6	1.2	0.4	0.3	0	41.7	35.7	0	131	115	0	34	32	34
2025	10	8	13	10	30	29.9	-2.2	1.2	0.3	0.2	0	42.1	35.7	0	132	116	0	34	33	34
2025	10	8	13	20	30	28.9	-2.8	1.201	0.3	0.2	0	42.1	36.1	0	132	117	0	34	33	33
2025	10	8	13	30	30	29.2	-3	1.201	0.5	0.4	0	42.6	35.7	0	132	116	0	33	33	34
2025	10	8	13	40	30	29	-2.5	1.2	0.3	0.2	0	42.6	36.1	0	133	117	0	34	33	33
2025	10	8	13	50	30	28.9	-2.1	1.2	0.3	0.2	0	43	37	0	134	118	0	34	32	34
2025	10	8	14	0	30	29.5	-2.3	1.199	0.4	0.3	0	43	36.5	0	134	118	0	34	33	34
2025	10	8	14	10	30	29.6	-1.3	1.2	0.4	0.3	0	43.4	37	0	135	119	0	34	33	34
2025	10	8	14	20	30	29.5	-2.5	1.2	0.3	0.2	0	44.3	37.8	0	136	120	0	33	32	33
2025	10	8	14	30	30	29.4	-2.6	1.199	0.3	0.2	0	44.3	37	0	136	120	0	33	34	33
2025	10	8	14	40	30	29.6	-2.6	1.201	0.3	0.2	0	43.9	37.8	0	136	121	0	34	33	34
2025	10	8	14	50	30	28.9	-1.9	1.201	0.3	0.2	0	44.7	37.8	0	137	121	0	33	33	33
2025	10	8	15	0	30	29.2	-2.3	1.201	0.3	0.2	0	44.3	38.7	0	137	122	0	34	32	34
2025	10	8	15	10	30	28.8	-3.1	1.2	0.3	0.2	0	44.7	38.3	0	138	122	0	34	33	34
2025	10	8	15	20	30	29.2	-2.8	1.2	0.3	0.2	0	45.2	38.7	0	139	123	0	34	33	34
2025	10	8	15	30	30	28.9	-2.7	1.199	0.4	0.3	0	45.2	38.7	0	139	123	0	34	33	34
2025	10	8	15	40	30	30	-2.1	1.199	0.3	0.2	0	45.2	38.7	0	139	123	0	34	33	33
2025	10	8	15	50	30	29.3	-2.4	1.199	0.3	0.2	0	45.2	38.7	0	139	123	0	34	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	8	16	0	30	29.4	-3.4	1.2	0.5	0.4	0	45.6	39.1	0	140	124	0	34	33	34
2025	10	8	16	10	30	29.3	-3.2	1.2	0.4	0.3	0	45.6	39.6	0	140	124	0	34	32	33
2025	10	8	16	20	30	30.5	-2.6	1.199	0.3	0.2	0	45.6	39.1	0	140	124	0	34	33	34
2025	10	8	16	30	30	29.5	-2.3	1.198	0.5	0.4	0	45.6	39.1	0	140	124	0	34	33	34
2025	10	8	16	40	30	29.1	-1.4	1.199	0.3	0.2	0	45.2	38.7	0	139	123	0	34	33	33
2025	10	8	16	50	30	29.5	-2.8	1.2	0.3	0.2	0	45.2	38.7	0	139	123	0	34	33	33
2025	10	8	17	0	30	29.5	-2	1.2	0.3	0.2	0	46.4	38.7	0	141	123	0	33	33	33
2025	10	8	17	10	30	28.8	-3.8	1.198	0.4	0.3	0	45.6	38.7	0	140	122	0	34	32	33
2025	10	8	17	20	30	29.7	-2.9	1.198	0.4	0.3	0	45.6	38.3	0	140	121	0	34	32	33
2025	10	8	17	30	30	28.6	-2.1	1.199	0.3	0.2	0	45.2	38.3	0	139	121	0	34	32	34
2025	10	8	17	40	30	29.3	-2.8	1.199	0.4	0.3	0	45.2	37.8	0	139	121	0	34	33	34
2025	10	8	17	50	30	28.2	-2.8	1.2	0.3	0.2	0	45.2	37.8	0	139	120	0	34	32	34
2025	10	8	18	0	30	29.6	-1.3	1.2	0.4	0.3	0	45.2	37.8	0	139	120	0	34	32	35
2025	10	8	18	10	30	28.8	-3.4	1.199	0.4	0.3	0	44.7	37.8	0	138	120	0	34	32	34
2025	10	8	18	20	30	29.8	-2.6	1.199	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	34
2025	10	8	18	30	30	29.2	-3.5	1.198	0.5	0.4	0	45.2	37	0	138	119	0	33	33	34
2025	10	8	18	40	30	29.2	-2.4	1.198	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	8	18	50	30	29.5	-1.5	1.199	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	8	19	0	30	29.6	-1.8	1.198	0.3	0.2	0	44.7	37.8	0	138	120	0	34	32	33
2025	10	8	19	10	30	30.4	-1.9	1.199	0.4	0.3	0	45.2	37.8	0	139	121	0	34	33	34
2025	10	8	19	20	30	30	-3.3	1.198	0.3	0.2	0	45.2	37.8	0	139	120	0	34	32	33
2025	10	8	19	30	30	30.7	-1.9	1.198	0.4	0.3	0	45.2	37.4	0	139	120	0	34	33	34
2025	10	8	19	40	30	30.4	-3.9	1.2	0.5	0.4	0	45.2	37.4	0	139	119	0	34	32	33
2025	10	8	19	50	30	29.7	-3.2	1.199	0.3	0.2	0	45.2	37.8	0	138	120	0	33	32	33
2025	10	8	20	0	30	30.2	-3.4	1.198	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	8	20	10	30	29.6	-2.3	1.199	0.3	0.2	0	45.2	38.3	0	139	121	0	34	32	34
2025	10	8	20	20	30	30.1	-3.1	1.198	0.5	0.4	0	45.2	37.4	0	139	120	0	34	33	33
2025	10	8	20	30	30	30.2	-1.9	1.199	0.3	0.2	0	45.2	37.8	0	139	121	0	34	33	34
2025	10	8	20	40	30	30.8	-3.2	1.199	0.5	0.4	0	44.7	37	0	138	119	0	34	33	34
2025	10	8	20	50	30	29.7	-2.9	1.198	0.4	0.3	0	45.2	37.4	0	138	120	0	33	33	34
2025	10	8	21	0	30	29.1	-2.8	1.199	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	34
2025	10	8	21	10	30	29.2	-2.4	1.198	0.4	0.3	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	8	21	20	30	30.8	-2.2	1.199	0.4	0.3	0	44.7	37.4	0	138	120	0	34	33	34
2025	10	8	21	30	30	30.4	-1.6	1.198	0.4	0.3	0	44.3	37.4	0	138	120	0	35	33	34
2025	10	8	21	40	30	30.2	-2.7	1.199	0.4	0.3	0	45.6	37.8	0	140	121	0	34	33	33
2025	10	8	21	50	30	30	-2.7	1.198	0.4	0.3	0	44.7	37.8	0	138	121	0	34	33	34
2025	10	8	22	0	30	30.4	-2.2	1.198	0.4	0.3	0	45.2	37.8	0	139	121	0	34	33	33
2025	10	8	22	10	30	29.7	-2.4	1.198	0.4	0.3	0	46.4	37.8	0	141	121	0	33	33	33
2025	10	8	22	20	30	29.5	-2.5	1.198	0.3	0.2	0	45.6	37.8	0	140	121	0	34	33	33
2025	10	8	22	30	30	30.4	-3.6	1.198	0.4	0.3	0	45.6	38.3	0	140	121	0	34	32	34
2025	10	8	22	40	30	29.4	-3.2	1.198	0.3	0.2	0	45.6	37.4	0	140	120	0	34	33	33
2025	10	8	22	50	30	30.2	-2.4	1.198	0.3	0.2	0	46	37.8	0	141	121	0	34	33	33
2025	10	8	23	0	30	30.4	-3	1.198	0.4	0.3	0	45.2	37	0	139	120	0	34	34	34
2025	10	8	23	10	30	29.6	-3.4	1.199	0.3	0.2	0	46	37.4	0	140	120	0	33	33	34
2025	10	8	23	20	30	30.3	-3.3	1.198	0.4	0.3	0	45.6	37.8	0	140	120	0	34	32	34
2025	10	8	23	30	30	29.8	-2.6	1.199	0.3	0.2	0	45.2	37.4	0	139	120	0	34	33	34
2025	10	8	23	40	30	29.4	-2.9	1.198	0.3	0.2	0	45.2	37.4	0	139	120	0	34	33	34
2025	10	8	23	50	30	29.6	-1.9	1.198	0.4	0.3	0	46	37.8	0	140	120	0	33	32	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	9	0	0	30	30	-3	1.199	0.3	0.2	0	45.2	37	0	139	120	0	34	34	33
2025	10	9	0	10	30	30	-2.7	1.199	0.3	0.2	0	45.6	37.4	0	139	120	0	33	33	34
2025	10	9	0	20	30	29.9	-2.1	1.198	0.3	0.2	0	45.2	37.4	0	139	119	0	34	32	34
2025	10	9	0	30	30	29.9	-3.8	1.198	0.4	0.3	0	45.2	37.4	0	139	120	0	34	33	34
2025	10	9	0	40	30	29.8	-2.6	1.199	0.3	0.2	0	44.3	37	0	138	119	0	35	33	34
2025	10	9	0	50	30	29.6	-2.6	1.198	0.3	0.2	0	45.2	37.8	0	139	120	0	34	32	33
2025	10	9	1	0	30	29.5	-2.8	1.199	0.4	0.3	0	44.7	37.4	0	138	119	0	34	32	33
2025	10	9	1	10	30	30.7	-2.7	1.198	0.3	0.2	0	44.7	37	0	138	119	0	34	33	34
2025	10	9	1	20	30	30.1	-3	1.199	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	34
2025	10	9	1	30	30	29.2	-3.7	1.2	0.4	0.3	0	44.7	37	0	138	119	0	34	33	34
2025	10	9	1	40	30	28.9	-2.2	1.198	0.3	0.2	0	45.2	37	0	138	119	0	33	33	33
2025	10	9	1	50	30	29.3	-3.9	1.199	0.3	0.2	0	45.2	37	0	138	119	0	33	33	33
2025	10	9	2	0	30	30.8	-2.1	1.198	0.3	0.2	0	44.3	37	0	138	119	0	35	33	34
2025	10	9	2	10	30	29	-2.6	1.198	0.3	0.2	0	44.7	37	0	138	119	0	34	33	34
2025	10	9	2	20	30	29.6	-2.6	1.198	0.4	0.3	0	44.7	36.1	0	138	117	0	34	33	34
2025	10	9	2	30	30	30.3	-2.8	1.2	0.3	0.2	0	44.7	37	0	138	119	0	34	33	34
2025	10	9	2	40	30	30.5	-1.5	1.198	0.4	0.3	0	44.7	37	0	138	119	0	34	33	33
2025	10	9	2	50	30	29.7	-1.9	1.198	0.3	0.2	0	44.7	37	0	138	119	0	34	33	33
2025	10	9	3	0	30	29.6	-3.3	1.199	0.4	0.3	0	44.7	36.5	0	137	119	0	33	34	33
2025	10	9	3	10	30	29.7	-2.9	1.2	0.3	0.2	0	44.3	37	0	136	119	0	33	33	34
2025	10	9	3	20	30	30.7	-3.4	1.2	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	9	3	30	30	29.4	-3.4	1.199	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	9	3	40	30	30.2	-2.9	1.198	0.3	0.2	0	44.7	37	0	138	119	0	34	33	33
2025	10	9	3	50	30	28.7	-1.8	1.199	0.4	0.3	0	45.2	37.4	0	138	120	0	33	33	33
2025	10	9	4	0	30	29.6	-3	1.199	0.3	0.2	0	44.3	37.4	0	138	119	0	35	32	34
2025	10	9	4	10	30	28.9	-3.2	1.197	0.3	0.2	0	44.7	37	0	137	119	0	33	33	33
2025	10	9	4	20	30	29	-1.5	1.197	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	34
2025	10	9	4	30	30	29.2	-2.1	1.198	0.4	0.3	0	44.7	37.8	0	138	120	0	34	32	33
2025	10	9	4	40	30	30.3	-2.8	1.197	0.5	0.4	0	44.7	37	0	138	119	0	34	33	33
2025	10	9	4	50	30	30	-3.4	1.199	0.5	0.4	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	9	5	0	30	30	-3.4	1.2	0.3	0.2	0	44.3	37	0	137	119	0	34	33	33
2025	10	9	5	10	30	29.3	-1.8	1.2	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	34
2025	10	9	5	20	30	29.6	-3.3	1.2	0.4	0.3	0	44.3	37	0	137	119	0	34	33	33
2025	10	9	5	30	30	30.5	-2.5	1.2	0.3	0.2	0	44.7	37	0	137	119	0	33	33	33
2025	10	9	5	40	30	29.6	-2.9	1.2	0.3	0.2	0	44.3	37	0	138	119	0	35	33	33
2025	10	9	5	50	30	30.7	-3.2	1.2	0.4	0.3	0	44.3	37	0	137	119	0	34	33	33
2025	10	9	6	0	30	30.6	-3.8	1.2	0.3	0.2	0	44.3	36.5	0	137	118	0	34	33	34
2025	10	9	6	10	30	30.6	-2.5	1.2	0.4	0.3	0	44.3	37	0	137	119	0	34	33	33
2025	10	9	6	20	30	30	-3.1	1.2	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	9	6	30	30	30.8	-2.5	1.2	0.4	0.3	0	44.3	37	0	137	119	0	34	33	34
2025	10	9	6	40	30	30.2	-3.9	1.2	0.3	0.2	0	44.3	36.1	0	137	118	0	34	34	33
2025	10	9	6	50	30	29.9	-3.2	1.2	0.5	0.4	0	43.4	36.5	0	136	118	0	35	33	33
2025	10	9	7	0	30	29.8	-3.1	1.2	0.3	0.2	0	43.9	36.5	0	136	118	0	34	33	33
2025	10	9	7	10	30	30.2	-2.9	1.2	0.3	0.2	0	44.3	36.5	0	136	118	0	33	33	34
2025	10	9	7	20	30	29.6	-3.3	1.2	0.3	0.2	0	43.9	36.5	0	136	118	0	34	33	34
2025	10	9	7	30	30	30.1	-2.6	1.2	0.4	0.3	0	43.9	36.5	0	135	117	0	33	32	33
2025	10	9	7	40	30	29.1	-2.4	1.2	0.3	0.2	0	43.9	36.1	0	136	117	0	34	33	34
2025	10	9	7	50	30	30.1	-3.6	1.2	0.3	0.2	0	43	36.1	0	134	117	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	9	8	0	30	30.1	-2.1	1.2	0.4	0.3	0	43.4	36.1	0	135	117	0	34	33	34
2025	10	9	8	10	30	29.1	-3.2	1.199	0.3	0.2	0	43	35.7	0	134	116	0	34	33	34
2025	10	9	8	20	30	28.4	-1.7	1.199	0.3	0.2	0	43.4	36.1	0	135	117	0	34	33	34
2025	10	9	8	30	30	29	-2	1.198	0.4	0.3	0	43.4	36.1	0	135	117	0	34	33	34
2025	10	9	8	40	30	30.2	-1.7	1.199	0.4	0.3	0	43.9	37	0	136	119	0	34	33	33
2025	10	9	8	50	30	29.5	-1.8	1.197	0.4	0.3	0	43	36.5	0	135	118	0	35	33	33
2025	10	9	9	0	30	29.5	-2	1.198	0.3	0.2	0	43.4	36.1	0	135	117	0	34	33	34
2025	10	9	9	10	30	28.8	-3.6	1.197	0.3	0.2	0	43.4	36.5	0	135	117	0	34	32	34
2025	10	9	9	20	30	30.2	-2.6	1.2	0.3	0.2	0	43.4	36.1	0	135	117	0	34	33	33
2025	10	9	9	30	30	30	-3	1.199	0.5	0.4	0	43	35.7	0	134	116	0	34	33	34
2025	10	9	9	40	30	29.4	-2.1	1.199	0.3	0.2	0	43.4	37	0	135	118	0	34	32	34
2025	10	9	9	50	30	29.2	-2.1	1.199	0.3	0.2	0	43.4	36.1	0	135	117	0	34	33	33
2025	10	9	10	0	30	28.9	-2.7	1.199	0.3	0.2	0	43.4	36.5	0	135	117	0	34	32	33
2025	10	9	10	10	30	29.3	-2.3	1.199	0.3	0.2	0	43.4	37	0	135	118	0	34	32	34
2025	10	9	10	20	30	28.8	-2.6	1.197	0.3	0.2	0	44.3	37	0	137	119	0	34	33	33
2025	10	9	10	30	30	29.2	-2	1.198	0.3	0.2	0	43.9	37	0	136	118	0	34	32	34
2025	10	9	10	40	30	28.6	-2.6	1.2	0.4	0.3	0	43.9	36.5	0	135	118	0	33	33	34
2025	10	9	10	50	30	29.7	-2.1	1.199	0.3	0.2	0	43.4	37	0	135	118	0	34	32	34
2025	10	9	11	0	30	29.6	-2.6	1.198	0.4	0.3	0	43.9	36.5	0	136	118	0	34	33	33
2025	10	9	11	10	30	28.8	-2.1	1.198	0.3	0.2	0	43.9	36.5	0	136	118	0	34	33	34
2025	10	9	11	20	30	29.3	-1.9	1.198	0.3	0.2	0	43.9	37	0	137	119	0	35	33	33
2025	10	9	11	30	30	28.8	-1.9	1.199	0.3	0.2	0	43.9	36.5	0	136	118	0	34	33	34
2025	10	9	11	40	30	28.8	-2.6	1.199	0.4	0.3	0	43.9	36.5	0	136	118	0	34	33	33
2025	10	9	11	50	30	29.8	-3.8	1.199	0.3	0.2	0	43.9	36.5	0	136	118	0	34	33	34
2025	10	9	12	0	30	29.7	-1	1.198	0.3	0.2	0	43.9	37	0	137	119	0	35	33	34
2025	10	9	12	10	30	29.8	-2.1	1.199	0.3	0.2	0	44.3	36.5	0	137	118	0	34	33	34
2025	10	9	12	20	30	29.5	-2.5	1.2	0.3	0.2	0	43.9	37.4	0	136	119	0	34	32	34
2025	10	9	12	30	30	29.4	-2.9	1.198	0.3	0.2	0	43.9	36.5	0	136	118	0	34	33	33
2025	10	9	12	40	30	29.3	-1	1.198	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	9	12	50	30	30	-2.6	1.199	0.4	0.3	0	44.3	37.4	0	137	119	0	34	32	34
2025	10	9	13	0	30	28.7	-3.4	1.197	0.3	0.2	0	44.3	37	0	137	119	0	34	33	34
2025	10	9	13	10	30	28.9	-1.4	1.199	0.4	0.3	0	44.3	37.4	0	137	119	0	34	32	34
2025	10	9	13	20	30	28.6	-2.7	1.197	0.4	0.3	0	44.3	37	0	137	119	0	34	33	33
2025	10	9	13	30	30	29	-1.7	1.197	0.3	0.2	0	44.7	37.8	0	138	120	0	34	32	34
2025	10	9	13	40	30	29.3	-2.7	1.195	0.3	0.2	0	45.2	37.4	0	138	120	0	33	33	33
2025	10	9	13	50	30	29.3	-2.4	1.196	0.4	0.3	0	44.7	37.4	0	138	120	0	34	33	34
2025	10	9	14	0	30	29	-3	1.197	0.4	0.3	0	45.2	37.4	0	138	120	0	33	33	33
2025	10	9	14	10	30	29.3	-3.4	1.197	0.3	0.2	0	44.3	37.8	0	137	120	0	34	32	34
2025	10	9	14	20	30	29	-2.1	1.197	0.3	0.2	0	45.2	38.3	0	139	121	0	34	32	34
2025	10	9	14	30	30	28.5	-2.4	1.198	0.5	0.4	0	45.2	38.3	0	139	121	0	34	32	33
2025	10	9	14	40	30	28.2	-1.2	1.197	0.4	0.3	0	45.2	38.3	0	139	121	0	34	32	33
2025	10	9	14	50	30	29.2	-2.1	1.196	0.3	0.2	0	45.2	38.3	0	139	121	0	34	32	34
2025	10	9	15	0	30	30.4	-1.6	1.197	0.5	0.5	0	45.6	38.7	0	139	122	0	33	32	33
2025	10	9	15	10	30	29.2	-2.5	1.195	0.3	0.2	0	45.2	37.8	0	139	121	0	34	33	33
2025	10	9	15	20	30	29.3	-2.6	1.195	0.4	0.3	0	45.6	38.3	0	140	122	0	34	33	33
2025	10	9	15	30	30	29.6	-1.9	1.196	0.3	0.2	0	45.2	37.8	0	139	121	0	34	33	34
2025	10	9	15	40	30	29.3	-1.3	1.195	0.3	0.2	0	45.6	38.3	0	139	122	0	33	33	34
2025	10	9	15	50	30	28.8	-2.1	1.196	0.3	0.2	0	44.7	38.3	0	139	122	0	35	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	9	16	0	30	28.3	-3	1.194	0.4	0.3	0	45.6	38.7	0	140	122	0	34	32	34
2025	10	9	16	10	30	29.4	-2.1	1.194	0.5	0.4	0	46	38.7	0	140	122	0	33	32	34
2025	10	9	16	20	30	29.1	-3.5	1.196	0.4	0.3	0	45.2	38.3	0	139	122	0	34	33	33
2025	10	9	16	30	30	29.6	-2.4	1.194	0.3	0.2	0	45.6	38.3	0	139	121	0	33	32	33
2025	10	9	16	40	30	29.5	-1.8	1.194	0.3	0.2	0	45.6	38.3	0	140	122	0	34	33	34
2025	10	9	16	50	30	28.7	-1.7	1.195	0.3	0.2	0	45.2	37.4	0	139	120	0	34	33	33
2025	10	9	17	0	30	28.8	-2.6	1.194	0.5	0.4	0	45.2	37.8	0	139	121	0	34	33	34
2025	10	9	17	10	30	29.2	-2.6	1.195	0.3	0.2	0	45.2	37.4	0	139	120	0	34	33	34
2025	10	9	17	20	30	29.8	-2	1.195	0.3	0.2	0	45.6	37.8	0	139	120	0	33	32	33
2025	10	9	17	30	30	29.8	-2.6	1.194	0.3	0.2	0	45.6	37.8	0	139	120	0	33	32	34
2025	10	9	17	40	30	28.6	-2.1	1.195	0.3	0.2	0	44.7	37.8	0	138	120	0	34	32	34
2025	10	9	17	50	30	30.3	-2.6	1.192	0.4	0.3	0	45.6	38.3	0	140	121	0	34	32	33
2025	10	9	18	0	30	29.3	-3	1.195	0.4	0.3	0	44.3	37.4	0	138	120	0	35	33	34
2025	10	9	18	10	30	28.5	-2.2	1.193	0.5	0.4	0	45.2	38.3	0	139	121	0	34	32	33
2025	10	9	18	20	30	29.2	-2	1.193	0.4	0.3	0	46	38.3	0	140	121	0	33	32	33
2025	10	9	18	30	30	30	-2.8	1.194	0.5	0.4	0	45.6	37.4	0	139	120	0	33	33	33
2025	10	9	18	40	30	29.3	-2.1	1.193	0.4	0.3	0	45.2	37.8	0	139	120	0	34	32	34
2025	10	9	18	50	30	29.2	-3.6	1.194	0.4	0.3	0	45.6	38.3	0	140	121	0	34	32	34
2025	10	9	19	0	30	29.7	-3.1	1.193	0.4	0.3	0	45.2	38.3	0	139	121	0	34	32	34
2025	10	9	19	10	30	29.3	-1.8	1.193	0.3	0.2	0	45.6	37.8	0	140	121	0	34	33	34
2025	10	9	19	20	30	29.1	-2.9	1.193	0.3	0.2	0	45.6	38.3	0	140	122	0	34	33	33
2025	10	9	19	30	30	30.2	-2.6	1.194	0.3	0.2	0	45.6	38.7	0	140	122	0	34	32	33
2025	10	9	19	40	30	30	-1.3	1.194	0.5	0.4	0	46	38.7	0	141	122	0	34	32	33
2025	10	9	19	50	30	29.9	-2.6	1.193	0.3	0.2	0	45.6	37.8	0	140	121	0	34	33	33
2025	10	9	20	0	30	30.1	-2.2	1.194	0.5	0.4	0	45.6	37.8	0	140	122	0	34	34	34
2025	10	9	20	10	30	28.4	-2.2	1.193	0.4	0.3	0	45.6	38.3	0	140	122	0	34	33	34
2025	10	9	20	20	30	29.5	-2.3	1.194	0.5	0.4	0	45.6	38.3	0	140	121	0	34	32	34
2025	10	9	20	30	30	28	-2.6	1.193	0.3	0.2	0	46	38.3	0	141	122	0	34	33	34
2025	10	9	20	40	30	28.9	-2.7	1.193	0.3	0.2	0	46.4	38.7	0	141	123	0	33	33	33
2025	10	9	20	50	30	28.8	-2.6	1.192	0.3	0.2	0	44.7	38.7	0	137	122	0	33	32	34
2025	10	9	21	0	30	28.9	-2.7	1.193	0.3	0.2	0	46	38.7	0	141	123	0	34	33	34
2025	10	9	21	10	30	28.8	-1.6	1.193	0.4	0.3	0	46	38.7	0	141	123	0	34	33	34
2025	10	9	21	20	30	28.8	-2	1.192	0.4	0.3	0	46	38.7	0	141	123	0	34	33	34
2025	10	9	21	30	30	30.4	-2.7	1.191	0.4	0.3	0	46	38.7	0	141	123	0	34	33	33
2025	10	9	21	40	30	29	-2.8	1.193	0.3	0.2	0	46	39.1	0	141	123	0	34	32	34
2025	10	9	21	50	30	29.6	-2.1	1.192	0.4	0.3	0	46.4	38.7	0	141	122	0	33	32	33
2025	10	9	22	0	30	29.1	-1.8	1.193	0.4	0.3	0	46	38.7	0	140	122	0	33	32	33
2025	10	9	22	10	30	29.8	-2.1	1.194	0.3	0.2	0	45.6	38.3	0	140	122	0	34	33	33
2025	10	9	22	20	30	29.2	-2.7	1.191	0.5	0.4	0	45.6	38.3	0	140	121	0	34	32	34
2025	10	9	22	30	30	29.5	-2.3	1.192	0.3	0.2	0	46	38.3	0	140	121	0	33	32	33
2025	10	9	22	40	30	29.1	-1.3	1.192	0.4	0.3	0	46	38.7	0	141	122	0	34	32	34
2025	10	9	22	50	30	28.8	-3	1.193	0.6	0.5	0	45.6	38.7	0	140	122	0	34	32	34
2025	10	9	23	0	30	28.8	-1.8	1.193	0.4	0.3	0	44.7	37.8	0	139	121	0	35	33	34
2025	10	9	23	10	30	28.3	-2.7	1.192	0.3	0.2	0	45.6	38.3	0	140	122	0	34	33	33
2025	10	9	23	20	30	30.3	-2.3	1.192	0.3	0.2	0	45.2	38.3	0	139	122	0	34	33	34
2025	10	9	23	30	30	29.2	-2.9	1.192	0.3	0.2	0	45.2	37.8	0	139	121	0	34	33	33
2025	10	9	23	40	30	30	-2.5	1.191	0.5	0.4	0	45.6	38.3	0	140	121	0	34	32	33
2025	10	9	23	50	30	29.4	-1.9	1.192	0.5	0.5	0	45.2	37.8	0	139	121	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	10	0	0	30	29.8	-3	1.192	0.3	0.2	0	45.2	38.3	0	139	121	0	34	32	33
2025	10	10	0	10	30	29.3	-3	1.192	0.4	0.3	0	45.2	38.3	0	139	121	0	34	32	34
2025	10	10	0	20	30	29.3	-1.6	1.191	0.3	0.2	0	45.2	38.3	0	139	121	0	34	32	34
2025	10	10	0	30	30	28.9	-3	1.192	0.3	0.2	0	45.2	37.8	0	139	121	0	34	33	33
2025	10	10	0	40	30	30.1	-3.7	1.193	0.4	0.3	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	10	0	50	30	29.6	-2.6	1.192	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	10	1	0	30	29.1	-2.9	1.192	0.5	0.4	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	10	1	10	30	29.7	-4.2	1.192	0.4	0.3	0	44.7	37	0	138	119	0	34	33	34
2025	10	10	1	20	30	29.8	-3	1.192	0.4	0.3	0	44.3	37.4	0	137	120	0	34	33	33
2025	10	10	1	30	30	29	-2.5	1.192	0.3	0.2	0	44.7	37.8	0	138	120	0	34	32	33
2025	10	10	1	40	30	29.8	-2.6	1.192	0.3	0.2	0	44.7	37.8	0	138	120	0	34	32	34
2025	10	10	1	50	30	28.9	-2.2	1.192	0.3	0.2	0	44.7	37	0	138	120	0	34	34	34
2025	10	10	2	0	30	29.4	-2.1	1.192	0.4	0.3	0	44.3	37.8	0	137	120	0	34	32	33
2025	10	10	2	10	30	29.8	-3	1.192	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	10	2	20	30	29.8	-3.3	1.192	0.5	0.4	0	43.9	37	0	137	119	0	35	33	34
2025	10	10	2	30	30	29	-3	1.192	0.4	0.3	0	44.7	37.8	0	138	120	0	34	32	34
2025	10	10	2	40	30	29.8	-3	1.192	0.3	0.2	0	44.3	37	0	137	119	0	34	33	34
2025	10	10	2	50	30	29.5	-2.1	1.192	0.3	0.2	0	45.2	37.4	0	138	120	0	33	33	34
2025	10	10	3	0	30	28.9	-3.1	1.191	0.3	0.2	0	44.3	37.4	0	137	120	0	34	33	33
2025	10	10	3	10	30	29.7	-2	1.192	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	34
2025	10	10	3	20	30	29.8	-3.9	1.192	0.3	0.2	0	45.2	37.8	0	138	120	0	33	32	33
2025	10	10	3	30	30	29.1	-2.4	1.192	0.4	0.3	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	10	3	40	30	29.4	-2.1	1.192	0.5	0.4	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	10	3	50	30	28.8	-2.1	1.192	0.3	0.2	0	45.2	37.8	0	138	120	0	33	32	33
2025	10	10	4	0	30	29.1	-2.9	1.192	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	10	4	10	30	29	-3.3	1.191	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	10	4	20	30	28.6	-2.3	1.191	0.4	0.3	0	45.6	38.3	0	139	121	0	33	32	34
2025	10	10	4	30	30	29.3	-2.9	1.191	0.4	0.3	0	44.3	37.8	0	137	120	0	34	32	34
2025	10	10	4	40	30	29	-2.8	1.191	0.4	0.3	0	45.2	37.4	0	138	120	0	33	33	33
2025	10	10	4	50	30	29.2	-3.1	1.191	0.5	0.4	0	44.7	37	0	138	119	0	34	33	33
2025	10	10	5	0	30	29.9	-2.5	1.192	0.4	0.3	0	44.7	37.8	0	138	120	0	34	32	33
2025	10	10	5	10	30	29.8	-3.9	1.191	0.4	0.3	0	44.7	37.8	0	138	120	0	34	32	33
2025	10	10	5	20	30	29.6	-3	1.192	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	10	5	30	30	29	-2.3	1.192	0.3	0.2	0	44.3	37.4	0	137	120	0	34	33	34
2025	10	10	5	40	30	29.4	-3.7	1.192	0.3	0.2	0	44.7	37.4	0	137	120	0	33	33	34
2025	10	10	5	50	30	29.6	-2.7	1.192	0.5	0.4	0	44.7	37.8	0	138	120	0	34	32	33
2025	10	10	6	0	30	29.3	-2.7	1.192	0.5	0.4	0	45.2	37.8	0	138	120	0	33	32	33
2025	10	10	6	10	30	29.4	-2.8	1.191	0.4	0.3	0	44.3	37.4	0	136	119	0	33	32	33
2025	10	10	6	20	30	29.8	-3.4	1.192	0.3	0.2	0	44.3	37.4	0	137	119	0	34	32	34
2025	10	10	6	30	30	29.4	-2.4	1.192	0.4	0.3	0	44.3	37.4	0	137	119	0	34	32	33
2025	10	10	6	40	30	30.2	-3.3	1.194	0.3	0.2	0	43.9	37	0	136	119	0	34	33	34
2025	10	10	6	50	30	28.8	-2.9	1.192	0.5	0.4	0	44.3	37.4	0	137	119	0	34	32	34
2025	10	10	7	0	30	30	-2.8	1.192	0.4	0.3	0	44.7	37	0	137	119	0	33	33	33
2025	10	10	7	10	30	28.5	-2.8	1.193	0.3	0.2	0	43.9	37	0	136	118	0	34	32	34
2025	10	10	7	20	30	29.4	-2	1.193	0.3	0.2	0	43.9	37	0	136	119	0	34	33	33
2025	10	10	7	30	30	29.8	-3.1	1.193	0.3	0.2	0	44.7	37	0	138	118	0	34	32	34
2025	10	10	7	40	30	29.4	-3.8	1.194	0.3	0.2	0	44.3	36.5	0	137	117	0	34	32	33
2025	10	10	7	50	30	28.7	-2.8	1.192	0.4	0.3	0	44.3	36.5	0	137	118	0	34	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	10	8	0	30	28.9	-2.5	1.192	0.3	0.2	0	44.7	36.5	0	137	117	0	33	32	34
2025	10	10	8	10	30	29.4	-3	1.192	0.3	0.2	0	44.3	36.5	0	136	117	0	33	32	34
2025	10	10	8	20	30	29.3	-2.1	1.192	0.4	0.3	0	44.3	36.5	0	137	117	0	34	32	33
2025	10	10	8	30	30	29.3	-2.4	1.193	0.3	0.2	0	44.3	36.5	0	136	117	0	33	32	34
2025	10	10	8	40	30	29.7	-2.6	1.193	0.4	0.3	0	43.9	35.7	0	136	116	0	34	33	33
2025	10	10	8	50	30	28.7	-2.5	1.191	0.4	0.3	0	43.9	36.1	0	136	116	0	34	32	34
2025	10	10	9	0	30	28.9	-2.3	1.191	0.4	0.3	0	43.9	35.7	0	136	116	0	34	33	33
2025	10	10	9	10	30	28.8	-4.2	1.194	0.5	0.4	0	43.4	35.7	0	135	116	0	34	33	34
2025	10	10	9	20	30	28.9	-2.3	1.193	0.3	0.2	0	43.9	35.7	0	136	116	0	34	33	34
2025	10	10	9	30	30	29.9	-3.5	1.193	0.4	0.3	0	43.9	35.7	0	136	116	0	34	33	33
2025	10	10	9	40	30	29.5	-3.4	1.194	0.3	0.2	0	43.9	36.5	0	136	117	0	34	32	34
2025	10	10	9	50	30	29.1	-2.5	1.193	0.4	0.3	0	43.4	35.7	0	135	116	0	34	33	33
2025	10	10	10	0	30	28.2	-1.8	1.192	0.3	0.2	0	43.4	36.5	0	135	117	0	34	32	33
2025	10	10	10	10	30	29.2	-2.1	1.191	0.3	0.2	0	44.3	36.1	0	137	118	0	34	34	32
2025	10	10	10	20	30	29.7	-3.1	1.193	0.3	0.2	0	44.7	37	0	138	119	0	34	33	33
2025	10	10	10	30	30	29.1	-2.3	1.193	0.4	0.3	0	45.2	37	0	139	119	0	34	33	34
2025	10	10	10	40	30	28.5	-2.1	1.191	0.3	0.2	0	45.2	37.4	0	139	120	0	34	33	34
2025	10	10	10	50	30	29.2	-2.6	1.192	0.3	0.2	0	45.6	37.8	0	140	121	0	34	33	34
2025	10	10	11	0	30	28.8	-3.1	1.193	0.4	0.3	0	44.3	37	0	137	118	0	34	32	33
2025	10	10	11	10	30	28.4	-2	1.193	0.3	0.2	0	44.3	37	0	137	119	0	34	33	33
2025	10	10	11	20	30	29.2	-3.1	1.193	0.4	0.3	0	44.7	36.5	0	137	118	0	33	33	33
2025	10	10	11	30	30	28.8	-2.1	1.192	0.4	0.3	0	44.3	37	0	137	118	0	34	32	34
2025	10	10	11	40	30	29.7	-3.6	1.192	0.4	0.3	0	44.3	36.5	0	137	118	0	34	33	33
2025	10	10	11	50	30	29	-2.4	1.192	0.3	0.2	0	43.9	37	0	136	118	0	34	32	34
2025	10	10	12	0	30	29.8	-3	1.191	0.5	0.5	0	43.9	36.5	0	136	117	0	34	32	33
2025	10	10	12	10	30	29.6	-2.8	1.191	0.4	0.3	0	44.3	36.5	0	136	118	0	33	33	33
2025	10	10	12	20	30	29.1	-3.3	1.192	0.4	0.3	0	44.3	37	0	137	118	0	34	32	34
2025	10	10	12	30	30	28.8	-1.8	1.192	0.3	0.2	0	43.9	36.5	0	136	118	0	34	33	34
2025	10	10	12	40	30	29	-2.2	1.192	0.3	0.2	0	44.3	36.5	0	137	118	0	34	33	33
2025	10	10	12	50	30	28.6	-2.2	1.192	0.3	0.2	0	44.7	37	0	137	118	0	33	32	34
2025	10	10	13	0	30	28.7	-2.2	1.191	0.3	0.2	0	44.3	36.5	0	137	118	0	34	33	34
2025	10	10	13	10	30	29.5	-2.4	1.191	0.3	0.2	0	45.2	37.8	0	138	120	0	33	32	33
2025	10	10	13	20	30	28.9	-2.5	1.19	0.4	0.3	0	45.2	37.4	0	138	120	0	33	33	33
2025	10	10	13	30	30	29.4	-2.2	1.191	0.3	0.2	0	44.7	37	0	138	119	0	34	33	33
2025	10	10	13	40	30	29.1	-3	1.192	0.3	0.2	0	45.2	37	0	138	119	0	33	33	33
2025	10	10	13	50	30	29.7	-2.4	1.19	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	33
2025	10	10	14	0	30	29.3	-2.5	1.192	0.5	0.4	0	45.2	37	0	138	119	0	33	33	33
2025	10	10	14	10	30	29.1	-1.3	1.191	0.3	0.2	0	45.2	37.8	0	139	120	0	34	32	33
2025	10	10	14	20	30	28.4	-2.2	1.191	0.3	0.2	0	45.6	38.3	0	139	120	0	33	31	33
2025	10	10	14	30	30	29.2	-2.1	1.19	0.4	0.3	0	45.2	37.8	0	139	120	0	34	32	33
2025	10	10	14	40	30	29.1	-2.5	1.19	0.3	0.2	0	45.6	38.3	0	139	121	0	33	32	34
2025	10	10	14	50	30	29.8	-2.4	1.191	0.3	0.2	0	45.2	37.8	0	139	120	0	34	32	32
2025	10	10	15	0	30	28.6	-3	1.19	0.5	0.4	0	45.2	37.4	0	139	120	0	34	33	33
2025	10	10	15	10	30	29.6	-3	1.19	0.3	0.2	0	45.2	37.8	0	139	120	0	34	32	33
2025	10	10	15	20	30	28.9	-1.4	1.189	0.3	0.2	0	45.2	37.8	0	139	120	0	34	32	34
2025	10	10	15	30	30	28.9	-1.8	1.19	0.3	0.2	0	45.6	38.7	0	140	122	0	34	32	33
2025	10	10	15	40	30	29	-1.3	1.191	0.3	0.2	0	45.6	38.3	0	140	121	0	34	32	33
2025	10	10	15	50	30	28.8	-2.9	1.191	0.3	0.2	0	46	38.3	0	140	121	0	33	32	33

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	10	10	16	0	30	28.9	-1.4	1.189	0.3	0.2	0	45.6	37.8	0	140	121	0	34	33	34	
2025	10	10	16	10	30	30.2	-2.8	1.189	0.3	0.2	0	46	38.3	0	140	121	0	33	32	34	
2025	10	10	16	20	30	28.8	-4	1.19	0.3	0.2	0	45.2	37.4	0	139	120	0	34	33	33	
2025	10	10	16	30	30	29	-1.6	1.191	0.3	0.2	0	45.2	37.4	0	139	120	0	34	33	34	
2025	10	10	16	40	30	28.9	-1.8	1.188	0.4	0.3	0	44.7	37.4	0	138	119	0	34	32	33	
2025	10	10	16	50	30	29.5	-2.2	1.19	0.4	0.3	0	44.7	37.4	0	138	119	0	34	32	34	
2025	10	10	17	0	30	28.7	-1.9	1.189	0.4	0.3	0	44.3	37	0	138	119	0	35	33	34	
2025	10	10	17	10	30	30.2	-1.7	1.191	0.3	0.2	0	44.3	36.5	0	137	118	0	34	33	33	
2025	10	10	17	20	30	28.5	-2.6	1.19	0.3	0.2	0	43.9	36.5	0	136	117	0	34	32	33	
2025	10	10	17	30	30	29.9	-2.3	1.189	0.5	0.4	0	43.9	36.5	0	136	117	0	34	32	33	
2025	10	10	17	40	30	28.5	-3.4	1.189	0.4	0.3	0	44.3	36.1	0	136	117	0	33	33	34	
2025	10	10	17	50	30	30	-3.7	1.19	0.4	0.3	0	43.9	36.1	0	136	117	0	34	33	33	
2025	10	10	18	0	30	28.7	-2.2	1.189	0.3	0.2	0	43.9	36.1	0	136	117	0	34	33	33	
2025	10	10	18	10	30	30.5	-2.5	1.189	0.5	0.5	0	43.9	36.5	0	136	117	0	34	32	33	
2025	10	10	18	20	30	29.7	-2.4	1.189	0.4	0.3	0	44.3	36.5	0	137	117	0	34	32	33	
2025	10	10	18	30	30	30.1	-2.9	1.19	0.3	0.2	0	44.7	36.1	0	138	117	0	34	33	33	
2025	10	10	18	40	30	30	-2.6	1.191	0.4	0.3	0	44.3	36.1	0	137	117	0	34	33	33	
2025	10	10	18	50	30	29.7	-3.3	1.19	0.4	0.3	0	45.2	36.5	0	138	117	0	33	32	33	
2025	10	10	19	0	30	30.3	-2.2	1.19	0.5	0.4	0	44.7	36.5	0	138	118	0	34	33	33	
2025	10	10	19	10	30	30	-2.6	1.189	0.3	0.2	0	45.2	37	0	139	119	0	34	33	33	
2025	10	10	19	20	30	29.3	-2.7	1.189	0.3	0.2	0	45.2	37	0	139	119	0	34	33	33	
2025	10	10	19	30	30	29.5	-2.7	1.189	0.3	0.2	0	45.6	37.4	0	139	119	0	33	32	33	
2025	10	10	19	40	30	29.9	-3.6	1.189	0.4	0.3	0	45.6	37.4	0	139	119	0	33	32	33	
2025	10	10	19	50	30	28.6	-2.2	1.189	0.3	0.2	0	45.6	37.4	0	140	120	0	34	33	33	
2025	10	10	20	0	30	30.4	-3	1.189	0.3	0.2	0	45.6	37.8	0	140	120	0	34	32	33	
2025	10	10	20	10	30	29.2	-2.3	1.189	0.3	0.2	0	45.6	37.4	0	140	120	0	34	33	33	
2025	10	10	20	20	30	29.8	-2.7	1.188	0.3	0.2	0	46	37.8	0	140	120	0	33	32	33	
2025	10	10	20	30	30	30.2	-3.1	1.187	0.3	0.2	0	45.2	37	0	139	119	0	34	33	33	
2025	10	10	20	40	30	29.5	-2.9	1.189	0.5	0.4	0	46	37.4	0	140	120	0	33	33	33	
2025	10	10	20	50	30	29.6	-4.1	1.189	0.3	0.2	0	45.2	37	0	139	119	0	34	33	33	
2025	10	10	21	0	30	29.9	-3.1	1.188	0.3	0.2	0	45.6	37.8	0	140	120	0	34	32	33	
2025	10	10	21	10	30	29	-3.2	1.189	0.3	0.2	0	45.6	37.4	0	140	120	0	34	33	33	
2025	10	10	21	20	30	29.2	-3.2	1.188	0.3	0.2	0	45.6	37.4	0	140	119	0	34	32	33	
2025	10	10	21	30	30	30.1	-3.2	1.188	0.3	0.2	0	45.2	36.5	0	139	119	0	34	34	33	
2025	10	10	21	40	30	29.7	-1.2	1.189	0.3	0.2	0	46	37.4	0	140	120	0	33	33	33	
2025	10	10	21	50	30	29.3	-2.9	1.188	0.3	0.2	0	45.6	37.8	0	140	120	0	34	32	33	
2025	10	10	22	0	30	29.1	-1.5	1.189	0.3	0.2	0	45.6	37.4	0	140	120	0	34	33	33	
2025	10	10	22	10	30	29	-2.7	1.188	0.4	0.3	0	45.2	37.4	0	139	120	0	34	33	33	
2025	10	10	22	20	30	29.8	-2.2	1.189	0.3	0.2	0	45.6	37.8	0	140	120	0	34	32	33	
2025	10	10	22	30	30	28.8	-2.2	1.189	0.3	0.2	0	45.2	37	0	139	119	0	34	33	33	
2025	10	10	22	40	30	29.6	-3.6	1.189	0.4	0.3	0	44.7	37	0	138	119	0	34	33	33	
2025	10	10	22	50	30	30	-3.2	1.189	0.4	0.3	0	45.6	37	0	139	119	0	33	33	32	
2025	10	10	23	0	30	28.7	-2.3	1.189	0.4	0.3	0	45.2	37.4	0	139	119	0	34	32	33	
2025	10	10	23	10	30	29.8	-2.6	1.189	0.3	0.2	0	45.2	37.4	0	139	119	0	34	32	33	
2025	10	10	23	20	30	30.3	-3	1.189	0.4	0.3	0	45.2	37.4	0	139	119	0	34	32	33	
2025	10	10	23	30	30	29.6	-3.6	1.189	0.4	0.3	0	45.6	37.8	0	139	120	0	33	32	33	
2025	10	10	23	40	30	28.7	-2.6	1.188	0.5	0.4	0	45.2	37	0	139	119	0	34	33	33	
2025	10	10	23	50	30	29	-3.2	1.188	0.3	0.2	0	45.2	37.8	0	139	120	0	34	32	33	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	11	0	0	30	28.8	-2.4	1.188	0.4	0.3	0	45.2	37.8	0	139	120	0	34	32	34
2025	10	11	0	10	30	28.7	-2.7	1.187	0.3	0.2	0	45.2	37.4	0	139	119	0	34	32	34
2025	10	11	0	20	30	29.3	-2.5	1.189	0.4	0.3	0	45.6	37	0	139	119	0	33	33	33
2025	10	11	0	30	30	29.9	-2.6	1.189	0.4	0.3	0	45.2	37.4	0	139	120	0	34	33	33
2025	10	11	0	40	30	29.4	-2.8	1.188	0.3	0.2	0	44.7	37	0	139	119	0	35	33	33
2025	10	11	0	50	30	29.7	-2.6	1.19	0.3	0.2	0	45.6	37.4	0	139	119	0	33	32	34
2025	10	11	1	0	30	30.1	-3.6	1.189	0.5	0.4	0	44.7	37	0	138	119	0	34	33	33
2025	10	11	1	10	30	29.7	-2.6	1.189	0.4	0.3	0	44.7	37	0	138	119	0	34	33	32
2025	10	11	1	20	30	28.8	-2.7	1.189	0.5	0.4	0	45.2	37	0	138	119	0	33	33	33
2025	10	11	1	30	30	29.4	-3.1	1.189	0.3	0.2	0	44.7	36.5	0	138	118	0	34	33	34
2025	10	11	1	40	30	29.4	-2.6	1.189	0.3	0.2	0	45.2	37.4	0	138	119	0	33	32	33
2025	10	11	1	50	30	28.8	-2.6	1.189	0.4	0.3	0	44.7	37	0	137	118	0	33	32	33
2025	10	11	2	0	30	30.3	-2.9	1.19	0.3	0.2	0	45.2	37	0	138	118	0	33	32	33
2025	10	11	2	10	30	30.3	-3.2	1.191	0.4	0.3	0	43.9	37	0	137	118	0	35	32	33
2025	10	11	2	20	30	29.5	-2.9	1.191	0.3	0.2	0	44.3	37	0	137	118	0	34	32	33
2025	10	11	2	30	30	29.3	-3.2	1.19	0.3	0.2	0	45.2	36.5	0	138	118	0	33	33	33
2025	10	11	2	40	30	29.5	-2.4	1.189	0.4	0.3	0	44.7	37	0	137	118	0	33	32	33
2025	10	11	2	50	30	29.1	-3	1.189	0.5	0.4	0	44.3	37	0	137	118	0	34	32	33
2025	10	11	3	0	30	29.7	-4.3	1.189	0.3	0.2	0	44.7	36.1	0	137	117	0	33	33	33
2025	10	11	3	10	30	28.5	-1.6	1.188	0.4	0.3	0	44.7	37	0	138	118	0	34	32	33
2025	10	11	3	20	30	28.9	-2.8	1.188	0.3	0.2	0	44.3	36.5	0	137	118	0	34	33	33
2025	10	11	3	30	30	29.5	-1.7	1.189	0.3	0.2	0	44.3	37	0	137	118	0	34	32	34
2025	10	11	3	40	30	29.7	-3	1.188	0.3	0.2	0	44.3	36.5	0	137	118	0	34	33	33
2025	10	11	3	50	30	30.1	-3.2	1.188	0.5	0.4	0	43.9	37	0	136	118	0	34	32	33
2025	10	11	4	0	30	28.5	-2.6	1.187	0.4	0.3	0	44.3	37	0	137	118	0	34	32	33
2025	10	11	4	10	30	29.3	-2.2	1.188	0.4	0.3	0	44.7	37	0	137	118	0	33	32	33
2025	10	11	4	20	30	30.3	-3.2	1.188	0.3	0.2	0	44.3	36.5	0	137	118	0	34	33	33
2025	10	11	4	30	30	30.1	-3.2	1.188	0.5	0.4	0	44.7	36.1	0	137	117	0	33	33	33
2025	10	11	4	40	30	29.7	-3.6	1.191	0.5	0.4	0	44.3	36.1	0	136	117	0	33	33	34
2025	10	11	4	50	30	30.5	-1.9	1.19	0.3	0.2	0	44.3	36.5	0	137	118	0	34	33	33
2025	10	11	5	0	30	29.6	-2.5	1.19	0.3	0.2	0	44.7	37	0	137	118	0	33	32	34
2025	10	11	5	10	30	30.6	-2.6	1.19	0.3	0.2	0	43.9	36.5	0	136	117	0	34	32	34
2025	10	11	5	20	30	29.3	-2	1.19	0.3	0.2	0	44.7	36.5	0	138	118	0	34	33	33
2025	10	11	5	30	30	29	-2.2	1.189	0.5	0.4	0	44.7	37	0	137	118	0	33	32	33
2025	10	11	5	40	30	29.7	-2.6	1.19	0.3	0.2	0	44.7	36.5	0	137	118	0	33	33	34
2025	10	11	5	50	30	29.6	-3	1.19	0.3	0.2	0	44.7	36.5	0	137	117	0	33	32	33
2025	10	11	6	0	30	30.4	-3	1.189	0.3	0.2	0	44.7	37	0	137	118	0	33	32	33
2025	10	11	6	10	30	28.9	-2.5	1.188	0.3	0.2	0	44.7	36.5	0	137	117	0	33	32	34
2025	10	11	6	20	30	29.7	-1.8	1.188	0.3	0.2	0	44.7	36.5	0	137	118	0	33	33	33
2025	10	11	6	30	30	31.2	-2.6	1.188	0.3	0.2	0	45.2	37	0	138	118	0	33	32	33
2025	10	11	6	40	30	28.7	-3.4	1.188	0.3	0.2	0	44.3	36.5	0	137	118	0	34	33	33
2025	10	11	6	50	30	29.1	-2	1.189	0.3	0.2	0	43.9	36.1	0	136	117	0	34	33	33
2025	10	11	7	0	30	29.4	-3.6	1.189	0.5	0.4	0	43.9	36.1	0	136	116	0	34	32	34
2025	10	11	7	10	30	30.7	-2.6	1.189	0.3	0.2	0	43.4	36.1	0	135	116	0	34	32	34
2025	10	11	7	20	30	27.5	-2	1.189	0.3	0.2	0	43.4	36.1	0	135	116	0	34	32	33
2025	10	11	7	30	30	29	-3.2	1.189	0.4	0.3	0	43	35.3	0	134	115	0	34	33	33
2025	10	11	7	40	30	29	-2.9	1.188	0.5	0.4	0	42.6	34.8	0	133	114	0	34	33	33
2025	10	11	7	50	30	29.5	-2.7	1.189	0.3	0.2	0	43.4	35.7	0	134	115	0	33	32	34

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	10	11	8	0	30	29.7	-3.3	1.188	0.4	0.3	0	42.6	35.3	0	133	115	0	34	33	33	
2025	10	11	8	10	30	29.2	-3	1.189	0.3	0.2	0	42.1	34.8	0	132	114	0	34	33	33	
2025	10	11	8	20	30	29.7	-3	1.187	0.3	0.2	0	42.1	35.3	0	132	114	0	34	32	33	
2025	10	11	8	30	30	29.5	-1.9	1.189	0.4	0.3	0	42.1	35.3	0	132	114	0	34	32	33	
2025	10	11	8	40	30	30.2	-2	1.187	0.3	0.2	0	42.1	34.8	0	132	113	0	34	32	33	
2025	10	11	8	50	30	30.3	-2.9	1.187	0.4	0.3	0	41.7	34.8	0	131	113	0	34	32	34	
2025	10	11	9	0	30	29.4	-1.8	1.187	0.3	0.2	0	42.1	34.4	0	132	113	0	34	33	33	
2025	10	11	9	10	30	29.4	-3	1.187	0.4	0.3	0	42.1	34.8	0	131	113	0	33	32	34	
2025	10	11	9	20	30	30.7	-3.1	1.186	0.5	0.5	0	41.7	34.4	0	130	112	0	33	32	34	
2025	10	11	9	30	30	29.7	-3.3	1.186	0.4	0.3	0	41.7	34.4	0	131	112	0	34	32	33	
2025	10	11	9	40	30	30.9	-2.9	1.186	0.5	0.4	0	41.7	34.8	0	131	113	0	34	32	34	
2025	10	11	9	50	30	29.7	-3.3	1.186	0.4	0.3	0	42.1	34	0	131	112	0	33	33	33	
2025	10	11	10	0	30	30.1	-2.8	1.186	0.4	0.3	0	42.1	34.8	0	131	113	0	33	32	33	
2025	10	11	10	10	30	28.6	-1.7	1.186	0.4	0.3	0	41.7	34.4	0	131	113	0	34	33	33	
2025	10	11	10	20	30	28.8	-3.1	1.186	0.4	0.3	0	42.6	35.7	0	132	115	0	33	32	34	
2025	10	11	10	30	30	28.4	-1.8	1.186	0.3	0.2	0	41.7	34.4	0	131	113	0	34	33	33	
2025	10	11	10	40	30	30	-3.2	1.186	0.3	0.2	0	42.1	35.3	0	132	114	0	34	32	34	
2025	10	11	10	50	30	29	-2.6	1.185	0.3	0.2	0	42.6	35.3	0	132	114	0	33	32	33	
2025	10	11	11	0	30	30.1	-3.1	1.186	0.4	0.3	0	42.6	34.8	0	133	114	0	34	33	33	
2025	10	11	11	10	30	29.4	-3.1	1.185	0.3	0.2	0	43	35.3	0	133	115	0	33	33	33	
2025	10	11	11	20	30	28.9	-1.9	1.185	0.3	0.2	0	42.6	35.7	0	133	115	0	34	32	34	
2025	10	11	11	30	30	29	-2.1	1.185	0.3	0.2	0	42.6	34.8	0	132	113	0	33	32	32	
2025	10	11	11	40	30	28.8	-3	1.186	0.5	0.4	0	42.6	34.4	0	132	113	0	33	33	34	
2025	10	11	11	50	30	28.1	-2.7	1.185	0.4	0.3	0	42.1	34.4	0	132	113	0	34	33	32	
2025	10	11	12	0	30	29.1	-3	1.185	0.4	0.3	0	42.1	34.8	0	132	113	0	34	32	34	
2025	10	11	12	10	30	29.2	-2.9	1.185	0.4	0.3	0	42.1	34.8	0	132	113	0	34	32	33	
2025	10	11	12	20	30	29.3	-2.8	1.184	0.3	0.2	0	42.1	34.8	0	132	113	0	34	32	34	
2025	10	11	12	30	30	29.2	-3.9	1.184	0.4	0.3	0	42.1	34.8	0	132	113	0	34	32	33	
2025	10	11	12	40	30	29.3	-2.7	1.185	0.4	0.3	0	42.1	34.8	0	132	113	0	34	32	33	
2025	10	11	12	50	30	28.8	-2.6	1.184	0.3	0.2	0	42.1	34.4	0	132	113	0	34	33	33	
2025	10	11	13	0	30	28.6	-2.3	1.183	0.4	0.3	0	43	34.8	0	133	114	0	33	33	33	
2025	10	11	13	10	30	29.1	-3	1.183	0.2	0.2	0	42.6	34.8	0	133	114	0	34	33	33	
2025	10	11	13	20	30	29.5	-2.9	1.184	0.4	0.3	0	43	35.7	0	134	115	0	34	32	33	
2025	10	11	13	30	30	28.3	-1.2	1.183	0.3	0.2	0	43.4	35.7	0	134	115	0	33	32	33	
2025	10	11	13	40	30	28.8	-2.3	1.183	0.3	0.2	0	43.9	36.5	0	136	117	0	34	32	33	
2025	10	11	13	50	30	28.1	-2.7	1.182	0.3	0.2	0	45.2	37.4	0	138	119	0	33	32	34	
2025	10	11	14	0	30	29.6	-2.3	1.181	0.4	0.3	0	45.6	38.3	0	141	121	0	35	32	34	
2025	10	11	14	10	30	30.2	-3.5	1.181	0.4	0.3	0	47.3	40	0	144	125	0	34	32	33	
2025	10	11	14	20	30	29.2	-2.7	1.181	0.3	0.2	0	47.7	40.4	0	145	126	0	34	32	33	
2025	10	11	14	30	30	28.2	-2.6	1.18	0.3	0.2	0	47.7	40.4	0	145	126	0	34	32	33	
2025	10	11	14	40	30	29.3	-2.7	1.18	0.3	0.2	0	47.3	39.6	0	143	124	0	33	32	34	
2025	10	11	14	50	30	27.7	-1.9	1.181	0.3	0.2	0	46.9	39.6	0	143	124	0	34	32	34	
2025	10	11	15	0	30	28.6	-2.7	1.181	0.5	0.4	0	46.4	38.3	0	141	122	0	33	33	34	
2025	10	11	15	10	30	28.5	-1.8	1.18	0.4	0.3	0	45.6	37.8	0	140	121	0	34	33	33	
2025	10	11	15	20	30	28.9	-3	1.18	0.3	0.2	0	45.2	37.4	0	139	120	0	34	33	33	
2025	10	11	15	30	30	28.1	-2.5	1.179	0.3	0.2	0	45.6	37.8	0	140	121	0	34	33	33	
2025	10	11	15	40	30	29.1	-1.8	1.178	0.3	0.2	0	45.2	37.8	0	139	120	0	34	32	33	
2025	10	11	15	50	30	29.1	-1.5	1.178	0.3	0.2	0	45.2	37.4	0	139	120	0	34	33	33	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	11	16	0	30	28.8	-1.7	1.177	0.5	0.5	0	45.6	38.3	0	140	121	0	34	32	33
2025	10	11	16	10	30	29.1	-2.8	1.177	0.3	0.2	0	44.7	37.8	0	138	120	0	34	32	33
2025	10	11	16	20	30	29.4	-2.6	1.176	0.3	0.2	0	45.2	38.3	0	139	121	0	34	32	34
2025	10	11	16	30	30	30.5	-2.9	1.176	0.3	0.2	0	45.2	37.4	0	139	120	0	34	33	33
2025	10	11	16	40	30	28.4	-2.2	1.175	0.3	0.2	0	45.2	37.4	0	138	119	0	33	32	33
2025	10	11	16	50	30	28.9	-2.8	1.175	0.3	0.2	0	44.7	37	0	138	119	0	34	33	34
2025	10	11	17	0	30	29	-3.4	1.174	0.3	0.2	0	44.3	36.5	0	137	118	0	34	33	33
2025	10	11	17	10	30	30.4	-3.1	1.174	0.3	0.2	0	44.7	37	0	138	118	0	34	32	34
2025	10	11	17	20	30	29	-3	1.173	0.4	0.3	0	45.2	37	0	138	118	0	33	32	34
2025	10	11	17	30	30	28.3	-2.3	1.173	0.3	0.2	0	45.2	37.4	0	139	119	0	34	32	33
2025	10	11	17	40	30	29.3	-1.7	1.173	0.3	0.2	0	45.2	37	0	138	119	0	33	33	34
2025	10	11	17	50	30	27.9	-2.8	1.172	0.4	0.3	0	45.2	37	0	138	118	0	33	32	34
2025	10	11	18	0	30	28.4	-2.8	1.172	0.3	0.2	0	44.7	36.5	0	138	118	0	34	33	33
2025	10	11	18	10	30	28.6	-2.7	1.172	0.5	0.4	0	44.7	37	0	138	118	0	34	32	33
2025	10	11	18	20	30	28.3	-2.1	1.172	0.4	0.3	0	44.7	37	0	138	118	0	34	32	32
2025	10	11	18	30	30	28.5	-2.7	1.172	0.4	0.3	0	44.7	37	0	138	119	0	34	33	33
2025	10	11	18	40	30	29.5	-1.9	1.171	0.3	0.2	0	45.2	37	0	139	119	0	34	33	33
2025	10	11	18	50	30	28.7	-2.5	1.171	0.4	0.3	0	45.2	37.4	0	138	119	0	33	32	33
2025	10	11	19	0	30	29.7	-2.3	1.171	0.4	0.3	0	45.6	37	0	139	119	0	33	33	32
2025	10	11	19	10	30	28.9	-2.1	1.17	0.3	0.2	0	45.2	37.8	0	139	120	0	34	32	33
2025	10	11	19	20	30	28.3	-2.7	1.171	0.2	0.1	0	45.6	37.8	0	139	120	0	33	32	33
2025	10	11	19	30	30	29.4	-3.3	1.17	0.3	0.2	0	45.6	37.8	0	139	120	0	33	32	33
2025	10	11	19	40	30	28.3	-2.4	1.17	0.4	0.3	0	45.6	37.8	0	140	120	0	34	32	33
2025	10	11	19	50	30	28.6	-2	1.17	0.3	0.2	0	45.2	37.4	0	140	120	0	35	33	34
2025	10	11	20	0	30	29	-2.7	1.17	0.5	0.4	0	45.2	37.8	0	139	120	0	34	32	34
2025	10	11	20	10	30	29.5	-2.7	1.17	0.3	0.2	0	44.3	37.8	0	137	120	0	34	32	33
2025	10	11	20	20	30	29.4	-2.1	1.169	0.4	0.3	0	45.2	37.4	0	139	120	0	34	33	33
2025	10	11	20	30	30	27.6	-2.1	1.169	0.3	0.2	0	45.6	37.8	0	140	120	0	34	32	33
2025	10	11	20	40	30	28.4	-2.3	1.169	0.4	0.3	0	45.6	37.4	0	140	120	0	34	33	34
2025	10	11	20	50	30	28	-3	1.169	0.3	0.2	0	45.6	38.3	0	140	121	0	34	32	33
2025	10	11	21	0	30	28.9	-2.3	1.169	0.5	0.4	0	45.2	37.4	0	140	120	0	35	33	33
2025	10	11	21	10	30	28.5	-3.7	1.169	0.5	0.4	0	45.6	37.4	0	140	120	0	34	33	33
2025	10	11	21	20	30	29.9	-3	1.169	0.4	0.3	0	45.2	37.8	0	139	120	0	34	32	33
2025	10	11	21	30	30	29.1	-3	1.169	0.3	0.2	0	45.6	37.4	0	140	120	0	34	33	33
2025	10	11	21	40	30	29	-2.7	1.168	0.3	0.2	0	46	37.8	0	140	120	0	33	32	34
2025	10	11	21	50	30	27.3	-2.9	1.168	0.3	0.2	0	45.2	37.8	0	139	120	0	34	32	34
2025	10	11	22	0	30	28.1	-4	1.168	0.4	0.3	0	44.7	37.8	0	139	120	0	35	32	33
2025	10	11	22	10	30	29	-3.3	1.168	0.4	0.3	0	45.2	37.4	0	139	119	0	34	32	33
2025	10	11	22	20	30	29.6	-2.7	1.168	0.4	0.3	0	44.7	37.4	0	138	119	0	34	32	33
2025	10	11	22	30	30	29.7	-2.6	1.168	0.3	0.2	0	45.2	37.4	0	139	119	0	34	32	34
2025	10	11	22	40	30	29.7	-3.1	1.167	0.3	0.2	0	45.2	37	0	139	119	0	34	33	33
2025	10	11	22	50	30	29.4	-3	1.167	0.3	0.2	0	45.2	37	0	139	119	0	34	33	34
2025	10	11	23	0	30	28	-1.9	1.167	0.4	0.3	0	45.6	37.4	0	139	120	0	33	33	33
2025	10	11	23	10	30	29.4	-2.8	1.167	0.3	0.2	0	45.2	37	0	139	119	0	34	33	33
2025	10	11	23	20	30	28.4	-2.3	1.166	0.4	0.3	0	44.7	37	0	138	119	0	34	33	33
2025	10	11	23	30	30	28.6	-3.1	1.166	0.5	0.4	0	45.2	37	0	139	119	0	34	33	33
2025	10	11	23	40	30	29.7	-3.3	1.166	0.4	0.3	0	44.7	37.4	0	138	119	0	34	32	33
2025	10	11	23	50	30	28.9	-3.2	1.166	0.3	0.2	0	44.7	36.5	0	138	118	0	34	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	12	0	0	30	29.4	-3.2	1.165	0.4	0.3	0	45.2	37	0	139	119	0	34	33	34
2025	10	12	0	10	30	28.7	-2.5	1.165	0.4	0.3	0	44.7	37.4	0	138	119	0	34	32	34
2025	10	12	0	20	30	28.5	-2.4	1.165	0.3	0.2	0	45.6	37.4	0	139	119	0	33	32	33
2025	10	12	0	30	30	28.7	-3.1	1.164	0.3	0.2	0	45.2	37.4	0	139	120	0	34	33	34
2025	10	12	0	40	30	28.3	-3.4	1.164	0.4	0.3	0	45.2	37.8	0	139	120	0	34	32	33
2025	10	12	0	50	30	27.6	-2.8	1.163	0.3	0.2	0	45.2	38.3	0	139	120	0	34	31	33
2025	10	12	1	0	30	29	-2.6	1.161	0.5	0.4	0	45.2	37.4	0	139	120	0	34	33	33
2025	10	12	1	10	30	27.7	-2.3	1.161	0.5	0.4	0	45.2	37.8	0	139	120	0	34	32	33
2025	10	12	1	20	30	27.2	-2.1	1.16	0.4	0.3	0	45.2	36.5	0	139	119	0	34	34	33
2025	10	12	1	30	30	28.1	-1.4	1.16	0.5	0.5	0	45.2	37.4	0	139	120	0	34	33	33
2025	10	12	1	40	30	27.1	-3	1.16	0.4	0.3	0	45.2	37	0	139	119	0	34	33	33
2025	10	12	1	50	30	28.2	-0.9	1.16	0.5	0.4	0	45.2	37	0	139	119	0	34	33	34
2025	10	12	2	0	30	29	-1.6	1.16	0.5	0.4	0	45.2	37	0	139	119	0	34	33	34
2025	10	12	2	10	30	28.7	-2.8	1.159	0.3	0.2	0	45.2	37	0	139	119	0	34	33	34
2025	10	12	2	20	30	27.9	-2.8	1.159	0.3	0.2	0	45.2	37.8	0	139	120	0	34	32	34
2025	10	12	2	30	30	29.4	-2.7	1.159	0.4	0.3	0	45.2	37	0	139	119	0	34	33	33
2025	10	12	2	40	30	29.1	-3.2	1.159	0.4	0.3	0	45.2	37.4	0	139	120	0	34	33	34
2025	10	12	2	50	30	28	-2.4	1.158	0.5	0.5	0	45.6	37.4	0	140	120	0	34	33	33
2025	10	12	3	0	30	26	-2.4	1.158	0.4	0.3	0	45.6	37.8	0	140	120	0	34	32	34
2025	10	12	3	10	30	27.7	-4.1	1.158	0.4	0.3	0	44.7	37.4	0	138	119	0	34	32	34
2025	10	12	3	20	30	29	-2.6	1.158	0.4	0.3	0	44.7	37.8	0	138	120	0	34	32	34
2025	10	12	3	30	30	28.4	-2.5	1.158	0.3	0.2	0	44.7	37.8	0	138	120	0	34	32	33
2025	10	12	3	40	30	28.8	-3.5	1.158	0.3	0.2	0	44.7	37	0	138	119	0	34	33	33
2025	10	12	3	50	30	27.2	-1.9	1.158	0.3	0.2	0	44.7	37.4	0	138	120	0	34	33	34
2025	10	12	4	0	30	27.9	-1.8	1.157	0.3	0.2	0	44.7	37.8	0	138	120	0	34	32	33
2025	10	12	4	10	30	29.1	-2.6	1.157	0.4	0.3	0	44.7	37	0	138	119	0	34	33	34
2025	10	12	4	20	30	28.4	-3.3	1.157	0.3	0.2	0	44.7	37.4	0	138	119	0	34	32	34
2025	10	12	4	30	30	28.8	-2.6	1.157	0.5	0.4	0	44.7	37	0	138	119	0	34	33	33
2025	10	12	4	40	30	28.2	-3.1	1.157	0.3	0.2	0	44.3	37.4	0	136	119	0	33	32	34
2025	10	12	4	50	30	29.1	-2.2	1.156	0.3	0.2	0	44.7	37.4	0	138	119	0	34	32	34
2025	10	12	5	0	30	27.9	-2.2	1.156	0.3	0.2	0	44.7	37.4	0	138	119	0	34	32	33
2025	10	12	5	10	30	29	-2.1	1.156	0.5	0.4	0	44.7	37	0	138	119	0	34	33	33
2025	10	12	5	20	30	28.3	-2.4	1.156	0.5	0.4	0	44.7	37.8	0	138	120	0	34	32	33
2025	10	12	5	30	30	27.5	-2.6	1.156	0.3	0.2	0	44.7	37	0	137	119	0	33	33	33
2025	10	12	5	40	30	28.9	-2.5	1.156	0.5	0.4	0	44.3	37.4	0	137	119	0	34	32	34
2025	10	12	5	50	30	28	-2.4	1.156	0.3	0.2	0	44.7	37	0	138	119	0	34	33	33
2025	10	12	6	0	30	28.9	-2.5	1.156	0.5	0.4	0	44.3	37	0	137	119	0	34	33	33
2025	10	12	6	10	30	29.1	-3.5	1.155	0.5	0.4	0	44.3	37	0	137	119	0	34	33	34
2025	10	12	6	20	30	27.1	-2.4	1.155	0.5	0.4	0	43.4	37.4	0	134	119	0	33	32	33
2025	10	12	6	30	30	27.1	-2.2	1.155	0.3	0.2	0	44.3	37	0	137	119	0	34	33	33
2025	10	12	6	40	30	27.8	-2.4	1.155	0.5	0.4	0	44.3	37	0	137	119	0	34	33	34
2025	10	12	6	50	30	28.9	-3.5	1.155	0.4	0.3	0	45.2	36.5	0	138	118	0	33	33	33
2025	10	12	7	0	30	28.5	-2.6	1.154	0.3	0.2	0	44.7	37	0	138	118	0	34	32	33
2025	10	12	7	10	30	27.6	-1.8	1.154	0.4	0.3	0	44.7	37	0	138	118	0	34	32	33
2025	10	12	7	20	30	28.4	-2.4	1.154	0.3	0.2	0	44.7	36.1	0	138	117	0	34	33	33
2025	10	12	7	30	30	29.2	-2.3	1.154	0.3	0.2	0	44.3	36.1	0	136	116	0	33	32	34
2025	10	12	7	40	30	27.3	-1.6	1.154	0.4	0.3	0	44.7	36.5	0	137	117	0	33	32	33
2025	10	12	7	50	30	28.6	-2.4	1.153	0.5	0.4	0	43.9	35.7	0	136	116	0	34	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	12	8	0	30	29.3	-2.6	1.153	0.4	0.3	0	43.4	35.3	0	135	115	0	34	33	33
2025	10	12	8	10	30	28.4	-3	1.153	0.4	0.3	0	43.9	35.3	0	135	115	0	33	33	33
2025	10	12	8	20	30	27.4	-2.6	1.153	0.3	0.2	0	43.4	35.3	0	135	115	0	34	33	34
2025	10	12	8	30	30	27.2	-2.8	1.153	0.5	0.4	0	43	36.1	0	135	116	0	35	32	34
2025	10	12	8	40	30	29.3	-1.6	1.153	0.5	0.4	0	43.4	35.7	0	135	115	0	34	32	34
2025	10	12	8	50	30	27.6	-1.9	1.153	0.3	0.2	0	43.4	35.3	0	134	115	0	33	33	33
2025	10	12	9	0	30	28.5	-3.4	1.153	0.3	0.2	0	43	35.3	0	134	115	0	34	33	33
2025	10	12	9	10	30	28.7	-2.3	1.152	0.4	0.3	0	43	35.7	0	134	115	0	34	32	33
2025	10	12	9	20	30	27.1	-2.2	1.152	0.3	0.2	0	43	35.3	0	134	115	0	34	33	33
2025	10	12	9	30	30	28.9	-3.4	1.152	0.3	0.2	0	43.4	35.3	0	134	114	0	33	32	34
2025	10	12	9	40	30	27	-3.5	1.151	0.3	0.2	0	43	35.3	0	134	115	0	34	33	34
2025	10	12	9	50	30	28.3	-1.6	1.151	0.5	0.4	0	43	35.3	0	134	115	0	34	33	34
2025	10	12	10	0	30	28.6	-3.1	1.149	0.3	0.2	0	42.6	35.7	0	134	115	0	35	32	33
2025	10	12	10	10	30	28	-3.1	1.149	0.5	0.4	0	43	35.3	0	134	115	0	34	33	33
2025	10	12	10	20	30	27.1	-2.2	1.149	0.3	0.2	0	43	35.3	0	134	115	0	34	33	34
2025	10	12	10	30	30	27.7	-3.1	1.148	0.3	0.2	0	42.6	35.3	0	133	114	0	34	32	33
2025	10	12	10	40	30	29.2	-3	1.148	0.5	0.4	0	43	36.1	0	134	116	0	34	32	33
2025	10	12	10	50	30	27.6	-2.7	1.148	0.4	0.3	0	43.4	35.7	0	134	115	0	33	32	33
2025	10	12	11	0	30	27.2	-3.9	1.148	0.5	0.4	0	43	35.3	0	134	115	0	34	33	34
2025	10	12	11	10	30	28.1	-2.9	1.148	0.3	0.2	0	42.6	35.7	0	133	115	0	34	32	33
2025	10	12	11	20	30	28.8	-3.2	1.147	0.4	0.3	0	42.1	34.8	0	132	113	0	34	32	33
2025	10	12	11	30	30	30.4	-3.9	1.147	0.4	0.3	0	42.1	34.4	0	133	113	0	35	33	34
2025	10	12	11	40	30	27.5	-2.1	1.147	0.3	0.2	0	42.6	35.3	0	133	114	0	34	32	34
2025	10	12	11	50	30	30	-2.5	1.147	0.3	0.2	0	42.6	35.3	0	133	114	0	34	32	33
2025	10	12	12	0	30	28.4	-2.3	1.147	0.3	0.2	0	42.6	34.8	0	133	114	0	34	33	34
2025	10	12	12	10	30	28.2	-2.2	1.147	0.4	0.3	0	42.6	34.8	0	133	113	0	34	32	34
2025	10	12	12	20	30	29	-3	1.147	0.4	0.3	0	42.6	34.8	0	133	114	0	34	33	34
2025	10	12	12	30	30	28.7	-2.2	1.147	0.3	0.2	0	42.6	34.4	0	133	114	0	34	34	34
2025	10	12	12	40	30	29	-3.1	1.146	0.5	0.5	0	43	34.8	0	133	114	0	33	33	33
2025	10	12	12	50	30	27.6	-3.1	1.146	0.5	0.4	0	42.6	34.8	0	133	114	0	34	33	33
2025	10	12	13	0	30	28.7	-3.3	1.146	0.4	0.3	0	42.6	34.4	0	133	113	0	34	33	33
2025	10	12	13	10	30	28	-2.7	1.146	0.4	0.3	0	42.1	34.4	0	132	113	0	34	33	33
2025	10	12	13	20	30	27.4	-2.8	1.146	0.3	0.2	0	42.6	34.8	0	133	114	0	34	33	33
2025	10	12	13	30	30	28.4	-2.7	1.146	0.4	0.3	0	42.6	34.8	0	133	114	0	34	33	34
2025	10	12	13	40	30	29.5	-4.1	1.146	0.5	0.4	0	43.9	36.1	0	136	117	0	34	33	33
2025	10	12	13	50	30	28.4	-2.6	1.146	0.5	0.4	0	42.6	34.8	0	133	114	0	34	33	34
2025	10	12	14	0	30	27.3	-3.7	1.146	0.4	0.3	0	43	35.3	0	134	114	0	34	32	34
2025	10	12	14	10	30	28.7	-2	1.146	0.3	0.2	0	42.6	34.8	0	133	114	0	34	33	33
2025	10	12	14	20	30	27.9	-3.1	1.145	0.4	0.3	0	43	35.7	0	134	115	0	34	32	33
2025	10	12	14	30	30	28.6	-3.1	1.145	0.4	0.3	0	43	34.8	0	133	114	0	33	33	34
2025	10	12	14	40	30	27.8	-2.2	1.145	0.3	0.2	0	43	35.3	0	134	115	0	34	33	33
2025	10	12	14	50	30	27.7	-2.8	1.145	0.3	0.2	0	43	35.3	0	134	115	0	34	33	33
2025	10	12	15	0	30	28.2	-2.8	1.145	0.5	0.4	0	43	35.7	0	134	115	0	34	32	33
2025	10	12	15	10	30	28	-3.4	1.145	0.5	0.5	0	43	35.7	0	134	115	0	34	32	33
2025	10	12	15	20	30	28	-4	1.144	0.3	0.2	0	43.4	34.8	0	134	114	0	33	33	34
2025	10	12	15	30	30	27.5	-3.1	1.144	0.4	0.3	0	43	35.3	0	134	115	0	34	33	33
2025	10	12	15	40	30	27.9	-2.6	1.144	0.3	0.2	0	43	35.7	0	134	115	0	34	32	33
2025	10	12	15	50	30	28.4	-3.3	1.144	0.3	0.2	0	43.4	35.3	0	135	115	0	34	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	12	16	0	30	27.9	-2.6	1.144	0.3	0.2	0	43.4	35.7	0	135	116	0	34	33	34
2025	10	12	16	10	30	27.5	-2.4	1.144	0.4	0.3	0	43.9	35.7	0	136	116	0	34	33	33
2025	10	12	16	20	30	27.5	-3.5	1.143	0.3	0.2	0	43.9	36.1	0	136	116	0	34	32	34
2025	10	12	16	30	30	27.8	-2.7	1.143	0.4	0.3	0	43.9	35.7	0	136	116	0	34	33	33
2025	10	12	16	40	30	27	-3.1	1.144	0.3	0.2	0	43.9	36.5	0	136	116	0	34	31	34
2025	10	12	16	50	30	28.2	-3	1.142	0.4	0.3	0	43.9	35.7	0	136	116	0	34	33	34
2025	10	12	17	0	30	27.6	-3.4	1.143	0.5	0.4	0	43.9	35.7	0	136	116	0	34	33	33
2025	10	12	17	10	30	28.2	-2.2	1.143	0.3	0.2	0	43.9	36.1	0	136	116	0	34	32	33
2025	10	12	17	20	30	27.7	-3.5	1.143	0.5	0.4	0	43.4	35.7	0	135	115	0	34	32	34
2025	10	12	17	30	30	27.3	-2.4	1.142	0.3	0.2	0	43.9	35.7	0	136	116	0	34	33	33
2025	10	12	17	40	30	28.5	-4.1	1.143	0.3	0.2	0	43.4	35.7	0	135	115	0	34	32	34
2025	10	12	17	50	30	29.2	-3	1.143	0.4	0.3	0	43.4	35.3	0	135	115	0	34	33	34
2025	10	12	18	0	30	28.1	-3	1.143	0.4	0.3	0	43.9	35.7	0	136	116	0	34	33	34
2025	10	12	18	10	30	28.6	-2.9	1.143	0.5	0.4	0	43.9	36.1	0	136	116	0	34	32	33
2025	10	12	18	20	30	28.9	-2.7	1.143	0.4	0.3	0	43.9	36.1	0	136	116	0	34	32	34
2025	10	12	18	30	30	28.6	-2.6	1.143	0.5	0.4	0	44.3	36.1	0	137	117	0	34	33	34
2025	10	12	18	40	30	28.7	-2.8	1.143	0.4	0.3	0	44.3	36.1	0	137	117	0	34	33	34
2025	10	12	18	50	30	28.8	-2.6	1.143	0.5	0.4	0	44.7	36.5	0	138	117	0	34	32	34
2025	10	12	19	0	30	28.2	-3.1	1.143	0.3	0.2	0	44.7	36.5	0	138	118	0	34	33	34
2025	10	12	19	10	30	28.5	-3.4	1.143	0.3	0.2	0	45.2	37.4	0	139	119	0	34	32	34
2025	10	12	19	20	30	27.1	-3	1.142	0.4	0.3	0	45.6	37.4	0	140	120	0	34	33	34
2025	10	12	19	30	30	27.7	-3.1	1.142	0.4	0.3	0	45.6	37.8	0	140	120	0	34	32	34
2025	10	12	19	40	30	28.3	-3	1.142	0.3	0.2	0	45.6	37	0	140	119	0	34	33	33
2025	10	12	19	50	30	27.8	-3.5	1.142	0.3	0.2	0	45.2	37.4	0	140	120	0	35	33	33
2025	10	12	20	0	30	29	-3.6	1.142	0.4	0.3	0	45.6	37.4	0	140	120	0	34	33	34
2025	10	12	20	10	30	29.5	-2.8	1.142	0.3	0.2	0	45.6	37.4	0	140	120	0	34	33	33
2025	10	12	20	20	30	27.1	-2.2	1.142	0.4	0.3	0	45.6	37.4	0	140	120	0	34	33	34
2025	10	12	20	30	30	28.6	-3.2	1.142	0.3	0.2	0	45.6	37	0	140	120	0	34	34	34
2025	10	12	20	40	30	27.2	-3.1	1.142	0.3	0.2	0	46	37.8	0	141	121	0	34	33	34
2025	10	12	20	50	30	28	-2.6	1.142	0.4	0.3	0	45.6	37	0	140	120	0	34	34	34
2025	10	12	21	0	30	27.2	-0.7	1.141	0.4	0.3	0	46	37.4	0	140	120	0	33	33	33
2025	10	12	21	10	30	28.3	-2.2	1.142	0.5	0.4	0	46	37.8	0	141	120	0	34	32	33
2025	10	12	21	20	30	28.9	-2.2	1.142	0.4	0.3	0	45.6	37.4	0	140	120	0	34	33	33
2025	10	12	21	30	30	28.6	-2.4	1.141	0.4	0.3	0	45.6	37.4	0	140	120	0	34	33	34
2025	10	12	21	40	30	28.6	-3.2	1.141	0.3	0.2	0	45.6	37.4	0	140	120	0	34	33	34
2025	10	12	21	50	30	27.8	-3.5	1.141	0.3	0.2	0	45.6	37.4	0	140	120	0	34	33	33
2025	10	12	22	0	30	28.4	-3.2	1.141	0.5	0.4	0	45.6	37.8	0	140	120	0	34	32	33
2025	10	12	22	10	30	28.4	-3.5	1.141	0.4	0.3	0	45.6	37.4	0	140	120	0	34	33	34
2025	10	12	22	20	30	28.5	-3.4	1.141	0.4	0.3	0	45.6	37.8	0	139	120	0	33	32	34
2025	10	12	22	30	30	28.2	-2.7	1.141	0.4	0.3	0	45.6	37.4	0	140	120	0	34	33	33
2025	10	12	22	40	30	28.1	-2.2	1.141	0.4	0.3	0	45.6	37.8	0	140	120	0	34	32	34
2025	10	12	22	50	30	29.1	-2.6	1.141	0.3	0.2	0	46	37.4	0	141	120	0	34	33	34
2025	10	12	23	0	30	28.5	-3	1.141	0.3	0.2	0	45.6	37.8	0	140	120	0	34	32	34
2025	10	12	23	10	30	27.6	-3.7	1.141	0.5	0.4	0	46	37.4	0	141	120	0	34	33	33
2025	10	12	23	20	30	27.3	-2.6	1.141	0.3	0.2	0	45.6	37.8	0	140	120	0	34	32	34
2025	10	12	23	30	30	28.5	-1.7	1.141	0.4	0.3	0	45.6	37.4	0	141	120	0	35	33	34
2025	10	12	23	40	30	27.2	-3.5	1.141	0.3	0.2	0	45.6	36.5	0	140	119	0	34	34	33
2025	10	12	23	50	30	28	-2.3	1.141	0.5	0.5	0	46	37.4	0	141	120	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	13	0	0	30	28.5	-2.1	1.141	0.4	0.3	0	45.6	37	0	140	119	0	34	33	34
2025	10	13	0	10	30	29	-3.5	1.141	0.5	0.4	0	45.6	37.4	0	140	120	0	34	33	33
2025	10	13	0	20	30	27.2	-2.4	1.141	0.4	0.3	0	45.6	37.4	0	140	120	0	34	33	35
2025	10	13	0	30	30	28.6	-3.3	1.141	0.4	0.3	0	45.6	37.4	0	140	120	0	34	33	34
2025	10	13	0	40	30	27.6	-3	1.141	0.4	0.3	0	45.6	37.4	0	140	120	0	34	33	34
2025	10	13	0	50	30	28.3	-2.8	1.141	0.3	0.2	0	45.2	37	0	139	119	0	34	33	34
2025	10	13	1	0	30	28.1	-3	1.14	0.3	0.2	0	45.6	37	0	140	119	0	34	33	33
2025	10	13	1	10	30	27.5	-2.8	1.14	0.4	0.3	0	45.6	37	0	140	120	0	34	34	33
2025	10	13	1	20	30	27.8	-1.8	1.141	0.4	0.3	0	45.6	37.8	0	140	120	0	34	32	34
2025	10	13	1	30	30	28.4	-3.4	1.14	0.4	0.3	0	45.2	37	0	139	119	0	34	33	34
2025	10	13	1	40	30	28.3	-3.8	1.14	0.4	0.3	0	45.2	37.4	0	139	119	0	34	32	33
2025	10	13	1	50	30	27.3	-1.8	1.14	0.3	0.2	0	45.2	37	0	139	119	0	34	33	33
2025	10	13	2	0	30	26.7	-3.3	1.14	0.3	0.2	0	45.2	37.4	0	139	120	0	34	33	34
2025	10	13	2	10	30	29	-3.7	1.14	0.3	0.2	0	44.7	37	0	138	118	0	34	32	33
2025	10	13	2	20	30	27.5	-3.1	1.14	0.3	0.2	0	45.6	37.4	0	140	120	0	34	33	34
2025	10	13	2	30	30	28.2	-3.4	1.14	0.5	0.4	0	45.2	37	0	139	119	0	34	33	34
2025	10	13	2	40	30	28.5	-3	1.14	0.3	0.2	0	45.6	37.4	0	140	120	0	34	33	33
2025	10	13	2	50	30	27.8	-2.2	1.14	0.3	0.2	0	45.6	37.4	0	140	120	0	34	33	34
2025	10	13	3	0	30	27.2	-3	1.14	0.3	0.2	0	45.2	37	0	139	119	0	34	33	33
2025	10	13	3	10	30	28.3	-3.3	1.14	0.4	0.3	0	44.7	37	0	138	119	0	34	33	34
2025	10	13	3	20	30	29.7	-3.3	1.14	0.3	0.2	0	44.7	36.5	0	138	118	0	34	33	33
2025	10	13	3	30	30	27.6	-2.8	1.14	0.3	0.2	0	45.2	37	0	139	119	0	34	33	34
2025	10	13	3	40	30	28.2	-2.7	1.14	0.3	0.2	0	43.9	37	0	137	118	0	35	32	33
2025	10	13	3	50	30	27.3	-1.7	1.14	0.4	0.3	0	45.2	36.5	0	139	118	0	34	33	34
2025	10	13	4	0	30	29.1	-3.9	1.14	0.5	0.4	0	45.2	36.5	0	138	118	0	33	33	33
2025	10	13	4	10	30	27.9	-2.4	1.14	0.4	0.3	0	44.7	36.5	0	138	118	0	34	33	34
2025	10	13	4	20	30	28	-2.8	1.14	0.3	0.2	0	44.7	37	0	138	118	0	34	32	34
2025	10	13	4	30	30	28.4	-1.4	1.14	0.3	0.2	0	44.7	36.1	0	137	117	0	33	33	34
2025	10	13	4	40	30	27.9	-2.2	1.14	0.3	0.2	0	44.7	37	0	138	118	0	34	32	33
2025	10	13	4	50	30	28.2	-2.2	1.14	0.4	0.3	0	44.3	36.1	0	137	117	0	34	33	34
2025	10	13	5	0	30	28	-2.2	1.14	0.3	0.2	0	44.7	37	0	138	118	0	34	32	34
2025	10	13	5	10	30	27.5	-3.1	1.14	0.4	0.3	0	44.3	36.5	0	137	118	0	34	33	34
2025	10	13	5	20	30	28.9	-3	1.14	0.3	0.2	0	44.3	36.1	0	137	117	0	34	33	34
2025	10	13	5	30	30	27.7	-2.4	1.14	0.4	0.3	0	44.7	36.5	0	138	118	0	34	33	34
2025	10	13	5	40	30	28.9	-2	1.14	0.4	0.3	0	44.3	36.5	0	137	117	0	34	32	34
2025	10	13	5	50	30	28.3	-2.3	1.14	0.4	0.3	0	44.3	36.1	0	138	117	0	35	33	34
2025	10	13	6	0	30	28.4	-2	1.14	0.4	0.3	0	44.7	36.1	0	138	117	0	34	33	34
2025	10	13	6	10	30	28	-2.6	1.14	0.4	0.3	0	44.3	36.1	0	137	117	0	34	33	34
2025	10	13	6	20	30	28.7	-2.6	1.14	0.4	0.3	0	44.3	36.1	0	137	117	0	34	33	33
2025	10	13	6	30	30	28.6	-2.6	1.14	0.3	0.2	0	44.3	36.1	0	137	117	0	34	33	34
2025	10	13	6	40	30	27.2	-2.2	1.14	0.5	0.4	0	44.3	36.1	0	137	117	0	34	33	34
2025	10	13	6	50	30	28.9	-1.7	1.14	0.4	0.3	0	44.3	36.1	0	137	117	0	34	33	34
2025	10	13	7	0	30	26.2	-2.2	1.14	0.5	0.4	0	43	35.7	0	135	116	0	35	33	34
2025	10	13	7	10	30	28.1	-2.8	1.14	0.5	0.4	0	43.4	35.7	0	135	116	0	34	33	34
2025	10	13	7	20	30	27.9	-3.5	1.14	0.4	0.3	0	43.4	35.3	0	135	115	0	34	33	34
2025	10	13	7	30	30	29.2	-3.6	1.14	0.3	0.2	0	42.6	35.3	0	134	115	0	35	33	34
2025	10	13	7	40	30	28	-2.6	1.14	0.3	0.2	0	43	34.8	0	134	114	0	34	33	34
2025	10	13	7	50	30	28.2	-2.4	1.14	0.3	0.2	0	42.1	34.8	0	133	114	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	13	8	0	30	29	-3	1.14	0.4	0.3	0	42.6	34.4	0	133	113	0	34	33	33
2025	10	13	8	10	30	28.3	-2.8	1.14	0.3	0.2	0	42.6	34.8	0	133	114	0	34	33	34
2025	10	13	8	20	30	27.4	-2.1	1.14	0.4	0.3	0	42.6	34.8	0	133	114	0	34	33	34
2025	10	13	8	30	30	27.9	-3.4	1.14	0.4	0.3	0	42.6	34.8	0	133	114	0	34	33	34
2025	10	13	8	40	30	28.3	-2.9	1.14	0.3	0.2	0	42.1	34.4	0	132	113	0	34	33	34
2025	10	13	8	50	30	26.4	-2.1	1.14	0.3	0.2	0	42.1	34.4	0	132	113	0	34	33	34
2025	10	13	9	0	30	27.7	-3	1.141	0.5	0.4	0	42.6	34	0	132	113	0	33	34	34
2025	10	13	9	10	30	27.1	-2.2	1.141	0.5	0.4	0	42.1	34	0	132	112	0	34	33	34
2025	10	13	9	20	30	28.2	-3.5	1.141	0.4	0.3	0	41.7	33.5	0	131	112	0	34	34	34
2025	10	13	9	30	30	27.1	-2.6	1.141	0.5	0.4	0	41.7	34	0	131	112	0	34	33	34
2025	10	13	9	40	30	27.6	-3.1	1.141	0.3	0.2	0	41.7	33.5	0	131	112	0	34	34	34
2025	10	13	9	50	30	28.7	-2.6	1.141	0.3	0.2	0	41.7	34.4	0	132	113	0	35	33	34
2025	10	13	10	0	30	27.8	-3.4	1.141	0.3	0.2	0	43	35.7	0	134	116	0	34	33	34
2025	10	13	10	10	30	28.8	-3	1.141	0.4	0.3	0	41.7	34	0	131	112	0	34	33	33
2025	10	13	10	20	30	28.3	-2.6	1.141	0.5	0.4	0	41.3	33.5	0	130	112	0	34	34	34
2025	10	13	10	30	30	28.1	-2.2	1.141	0.3	0.2	0	41.3	34	0	131	112	0	35	33	34
2025	10	13	10	40	30	28.8	-2.8	1.141	0.4	0.3	0	41.3	33.5	0	130	111	0	34	33	34
2025	10	13	10	50	30	28.8	-2.7	1.141	0.4	0.3	0	41.3	33.5	0	129	110	0	33	32	33
2025	10	13	11	0	30	27.5	-3.3	1.141	0.4	0.3	0	41.3	33.5	0	130	111	0	34	33	34
2025	10	13	11	10	30	27.8	-3.1	1.141	0.4	0.3	0	40.4	33.1	0	129	110	0	35	33	34
2025	10	13	11	20	30	27.8	-2.8	1.141	0.5	0.4	0	40.9	33.1	0	129	110	0	34	33	34
2025	10	13	11	30	30	27.8	-3.1	1.141	0.3	0.2	0	40.9	33.1	0	129	110	0	34	33	34
2025	10	13	11	40	30	28	-1.1	1.141	0.5	0.4	0	40	32.7	0	128	109	0	35	33	34
2025	10	13	11	50	30	28.2	-3.8	1.141	0.4	0.3	0	40.9	33.1	0	129	110	0	34	33	34
2025	10	13	12	0	30	28.2	-3.4	1.141	0.4	0.3	0	40.9	33.1	0	129	110	0	34	33	35
2025	10	13	12	10	30	27.1	-3.9	1.141	0.3	0.2	0	40.4	32.3	0	128	109	0	34	34	34
2025	10	13	12	20	30	28.9	-3.3	1.141	0.4	0.3	0	40.4	32.7	0	128	109	0	34	33	34
2025	10	13	12	30	30	29	-3.4	1.141	0.3	0.2	0	40.9	32.7	0	129	110	0	34	34	34
2025	10	13	12	40	30	27.9	-3.4	1.14	0.5	0.4	0	40.9	33.1	0	129	109	0	34	32	34
2025	10	13	12	50	30	27.5	-2.6	1.14	0.4	0.3	0	40.4	32.7	0	128	109	0	34	33	33
2025	10	13	13	0	30	28.4	-3	1.139	0.3	0.2	0	40.4	33.5	0	128	110	0	34	32	34
2025	10	13	13	10	30	26.7	-1.7	1.14	0.3	0.2	0	41.3	34	0	130	111	0	34	32	34
2025	10	13	13	20	30	27.4	-2.6	1.139	0.3	0.2	0	41.7	33.5	0	131	112	0	34	34	33
2025	10	13	13	30	30	27.1	-2.1	1.139	0.5	0.4	0	42.6	34.8	0	134	114	0	35	33	34
2025	10	13	13	40	30	27	-2.1	1.141	0.3	0.2	0	43	35.3	0	134	115	0	34	33	34
2025	10	13	13	50	30	27.9	-3	1.14	0.5	0.4	0	42.6	35.3	0	134	115	0	35	33	33
2025	10	13	14	0	30	27	-1.6	1.14	0.4	0.3	0	42.6	34.8	0	134	115	0	35	34	34
2025	10	13	14	10	30	27.5	-1.8	1.14	0.4	0.3	0	43	35.3	0	134	115	0	34	33	34
2025	10	13	14	20	30	28.3	-3.1	1.14	0.3	0.2	0	42.1	34.8	0	133	114	0	35	33	34
2025	10	13	14	30	30	27.9	-3.6	1.14	0.3	0.2	0	42.6	34.8	0	133	114	0	34	33	34
2025	10	13	14	40	30	28	-3	1.14	0.4	0.3	0	42.6	34.8	0	134	114	0	35	33	34
2025	10	13	14	50	30	27.8	-2.8	1.139	0.5	0.4	0	43	35.3	0	134	115	0	34	33	34
2025	10	13	15	0	30	28.4	-2.8	1.139	0.5	0.4	0	43	35.3	0	134	115	0	34	33	33
2025	10	13	15	10	30	27.8	-3	1.138	0.3	0.2	0	43	35.3	0	134	115	0	34	33	33
2025	10	13	15	20	30	28.6	-3	1.139	0.4	0.3	0	43.4	35.3	0	135	115	0	34	33	33
2025	10	13	15	30	30	27.5	-2.9	1.14	0.3	0.2	0	43	34.8	0	134	114	0	34	33	34
2025	10	13	15	40	30	27.4	-2.7	1.14	0.3	0.2	0	43	34.8	0	134	114	0	34	33	34
2025	10	13	15	50	30	27.9	-3.9	1.14	0.3	0.2	0	42.6	34.4	0	133	113	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	13	16	0	30	28	-2.7	1.14	0.5	0.4	0	43	34.8	0	134	114	0	34	33	34
2025	10	13	16	10	30	27.3	-3.6	1.14	0.4	0.3	0	42.6	34	0	133	113	0	34	34	34
2025	10	13	16	20	30	27.3	-3	1.139	0.5	0.4	0	42.1	34	0	132	113	0	34	34	34
2025	10	13	16	30	30	28	-3.4	1.138	0.3	0.2	0	42.6	34.8	0	133	114	0	34	33	34
2025	10	13	16	40	30	27.8	-3.3	1.139	0.3	0.2	0	42.6	34.8	0	133	114	0	34	33	34
2025	10	13	16	50	30	27	-3	1.14	0.4	0.3	0	42.6	34.8	0	133	114	0	34	33	33
2025	10	13	17	0	30	27	-2.4	1.139	0.4	0.3	0	42.6	34.8	0	134	114	0	35	33	34
2025	10	13	17	10	30	27.9	-2.5	1.139	0.3	0.2	0	43.4	35.3	0	135	115	0	34	33	34
2025	10	13	17	20	30	27.3	-1.5	1.138	0.4	0.3	0	43.9	35.3	0	135	115	0	33	33	34
2025	10	13	17	30	30	27.8	-2.8	1.14	0.4	0.3	0	43	35.3	0	135	115	0	35	33	34
2025	10	13	17	40	30	26.7	-2.1	1.139	0.3	0.2	0	43.9	35.7	0	136	116	0	34	33	33
2025	10	13	17	50	30	27.5	-2.1	1.139	0.4	0.3	0	43	35.3	0	135	115	0	35	33	34
2025	10	13	18	0	30	27.7	-2.7	1.14	0.3	0.2	0	43.4	35.3	0	135	115	0	34	33	33
2025	10	13	18	10	30	27.7	-2.2	1.14	0.3	0.2	0	44.3	35.7	0	137	116	0	34	33	34
2025	10	13	18	20	30	28.1	-2.9	1.139	0.3	0.2	0	44.3	36.1	0	137	117	0	34	33	34
2025	10	13	18	30	30	28.6	-1.2	1.139	0.3	0.2	0	44.3	36.1	0	138	117	0	35	33	34
2025	10	13	18	40	30	27.8	-3.4	1.139	0.3	0.2	0	44.3	35.7	0	138	117	0	35	34	33
2025	10	13	18	50	30	28.4	-3.4	1.14	0.4	0.3	0	45.2	36.5	0	140	119	0	35	34	34
2025	10	13	19	0	30	26.8	-3	1.14	0.4	0.3	0	45.6	37.4	0	140	120	0	34	33	34
2025	10	13	19	10	30	27.3	-2.6	1.139	0.3	0.2	0	45.6	37	0	140	120	0	34	34	33
2025	10	13	19	20	30	28.5	-1.9	1.139	0.3	0.2	0	45.6	37.4	0	140	120	0	34	33	34
2025	10	13	19	30	30	28	-3.4	1.139	0.5	0.5	0	45.6	37.4	0	140	120	0	34	33	34
2025	10	13	19	40	30	28.3	-3.5	1.14	0.4	0.3	0	45.6	37.4	0	140	120	0	34	33	34
2025	10	13	19	50	30	26.8	-2.4	1.138	0.5	0.4	0	45.6	37.8	0	140	120	0	34	32	34
2025	10	13	20	0	30	27.6	-2.5	1.14	0.3	0.2	0	45.6	37	0	140	120	0	34	34	34
2025	10	13	20	10	30	27.2	-2.4	1.139	0.3	0.2	0	46	37.8	0	141	121	0	34	33	34
2025	10	13	20	20	30	28.2	-3.6	1.14	0.5	0.4	0	45.2	37	0	140	120	0	35	34	33
2025	10	13	20	30	30	28.6	-2.4	1.139	0.5	0.4	0	45.6	37.4	0	140	120	0	34	33	34
2025	10	13	20	40	30	27.4	-2.6	1.14	0.5	0.4	0	45.2	36.5	0	139	119	0	34	34	34
2025	10	13	20	50	30	28.6	-3.7	1.14	0.4	0.3	0	45.2	37	0	139	118	0	34	32	33
2025	10	13	21	0	30	27.7	-1.7	1.139	0.3	0.2	0	45.2	36.5	0	139	118	0	34	33	34
2025	10	13	21	10	30	26.4	-2.6	1.141	0.4	0.3	0	44.7	37	0	139	119	0	35	33	34
2025	10	13	21	20	30	27.3	-2.9	1.14	0.3	0.2	0	45.6	37.4	0	140	119	0	34	32	35
2025	10	13	21	30	30	27	-2.5	1.14	0.4	0.3	0	45.6	36.1	0	140	118	0	34	34	34
2025	10	13	21	40	30	27.7	-2.6	1.14	0.3	0.2	0	45.2	37	0	140	119	0	35	33	33
2025	10	13	21	50	30	27.5	-2.2	1.14	0.3	0.2	0	45.6	37	0	140	119	0	34	33	34
2025	10	13	22	0	30	27.2	-3	1.139	0.4	0.3	0	45.6	37	0	140	119	0	34	33	34
2025	10	13	22	10	30	28.4	-3.6	1.139	0.5	0.4	0	44.7	36.5	0	139	118	0	35	33	34
2025	10	13	22	20	30	27.7	-1.8	1.14	0.3	0.2	0	45.6	37	0	140	119	0	34	33	34
2025	10	13	22	30	30	28.4	-1.7	1.14	0.3	0.2	0	45.2	37	0	140	119	0	35	33	33
2025	10	13	22	40	30	28.4	-2.2	1.14	0.4	0.3	0	45.6	36.5	0	140	119	0	34	34	34
2025	10	13	22	50	30	29	-2.5	1.139	0.3	0.2	0	45.6	36.1	0	140	118	0	34	34	34
2025	10	13	23	0	30	27.8	-3.2	1.139	0.3	0.2	0	44.7	36.5	0	139	119	0	35	34	33
2025	10	13	23	10	30	27.6	-3	1.139	0.5	0.4	0	45.6	36.5	0	140	118	0	34	33	34
2025	10	13	23	20	30	27.8	-3.2	1.14	0.5	0.5	0	45.2	36.1	0	139	117	0	34	33	34
2025	10	13	23	30	30	27.6	-3	1.138	0.3	0.2	0	45.2	36.5	0	139	118	0	34	33	34
2025	10	13	23	40	30	27.3	-2.2	1.14	0.3	0.2	0	44.7	36.5	0	139	118	0	35	33	34
2025	10	13	23	50	30	28.1	-2.9	1.139	0.3	0.2	0	45.2	36.5	0	139	118	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	14	0	0	30	27.7	-2.3	1.14	0.3	0.2	0	45.2	36.5	0	139	118	0	34	33	33
2025	10	14	0	10	30	27.5	-2.9	1.14	0.5	0.4	0	44.7	36.1	0	138	117	0	34	33	33
2025	10	14	0	20	30	26.7	-2.5	1.139	0.4	0.3	0	44.7	36.1	0	138	117	0	34	33	34
2025	10	14	0	30	30	28.3	-2.5	1.141	0.3	0.2	0	44.7	36.1	0	138	117	0	34	33	34
2025	10	14	0	40	30	27.3	-3.8	1.14	0.3	0.2	0	44.3	36.1	0	137	117	0	34	33	34
2025	10	14	0	50	30	27.5	-2.1	1.141	0.4	0.3	0	44.3	36.1	0	138	117	0	35	33	34
2025	10	14	1	0	30	27.2	-3	1.14	0.4	0.3	0	44.7	35.7	0	138	117	0	34	34	34
2025	10	14	1	10	30	27.1	-2.8	1.14	0.4	0.3	0	44.3	35.7	0	137	116	0	34	33	34
2025	10	14	1	20	30	28.5	-2.8	1.141	0.3	0.2	0	44.3	35.7	0	137	116	0	34	33	34
2025	10	14	1	30	30	27.2	-3.3	1.139	0.3	0.2	0	44.3	35.3	0	137	116	0	34	34	34
2025	10	14	1	40	30	27.9	-4.1	1.141	0.3	0.2	0	43.9	35.3	0	136	116	0	34	34	35
2025	10	14	1	50	30	28.5	-2.8	1.14	0.4	0.3	0	43.9	35.7	0	136	116	0	34	33	34
2025	10	14	2	0	30	27.5	-3.1	1.14	0.5	0.5	0	43.4	35.3	0	136	115	0	35	33	34
2025	10	14	2	10	30	27.2	-3.3	1.141	0.4	0.3	0	43.4	35.7	0	136	116	0	35	33	34
2025	10	14	2	20	30	28.6	-3.5	1.141	0.4	0.3	0	43.9	35.7	0	136	116	0	34	33	34
2025	10	14	2	30	30	28.8	-2.1	1.14	0.5	0.4	0	43.4	35.3	0	136	116	0	35	34	34
2025	10	14	2	40	30	28	-2.6	1.14	0.5	0.4	0	43.4	35.7	0	136	116	0	35	33	34
2025	10	14	2	50	30	27.2	-2.3	1.139	0.3	0.2	0	43.9	35.7	0	136	116	0	34	33	34
2025	10	14	3	0	30	28.1	-3.2	1.14	0.4	0.3	0	43.4	34.8	0	135	115	0	34	34	34
2025	10	14	3	10	30	27.4	-2.1	1.14	0.4	0.3	0	43.9	34.8	0	136	115	0	34	34	34
2025	10	14	3	20	30	28.9	-2.2	1.141	0.5	0.4	0	43.9	35.3	0	136	115	0	34	33	34
2025	10	14	3	30	30	28.3	-3.4	1.141	0.4	0.3	0	43.9	35.7	0	137	116	0	35	33	35
2025	10	14	3	40	30	27.3	-3.4	1.14	0.4	0.3	0	43.9	35.3	0	136	115	0	34	33	34
2025	10	14	3	50	30	27	-3	1.141	0.4	0.3	0	43.4	34.8	0	135	114	0	34	33	34
2025	10	14	4	0	30	27.5	-3.8	1.14	0.4	0.3	0	43.4	35.3	0	136	115	0	35	33	34
2025	10	14	4	10	30	28.4	-2.4	1.14	0.4	0.3	0	43.4	34.8	0	135	115	0	34	34	33
2025	10	14	4	20	30	28	-3.4	1.14	0.3	0.2	0	43	35.3	0	135	115	0	35	33	34
2025	10	14	4	30	30	27.8	-1.7	1.139	0.3	0.2	0	43	34.4	0	134	114	0	34	34	34
2025	10	14	4	40	30	27.7	-3.1	1.14	0.4	0.3	0	43	34.4	0	134	114	0	34	34	34
2025	10	14	4	50	30	27.1	-2.6	1.14	0.3	0.2	0	43.4	34.8	0	135	115	0	34	34	34
2025	10	14	5	0	30	27.6	-2.9	1.141	0.4	0.3	0	43.4	35.3	0	135	115	0	34	33	33
2025	10	14	5	10	30	27.9	-2.1	1.141	0.4	0.3	0	43	34.8	0	134	114	0	34	33	34
2025	10	14	5	20	30	27.5	-2.1	1.141	0.4	0.3	0	43.4	35.3	0	135	115	0	34	33	34
2025	10	14	5	30	30	28	-2.3	1.141	0.3	0.2	0	42.6	34.8	0	134	114	0	35	33	34
2025	10	14	5	40	30	27.4	-2.5	1.14	0.4	0.3	0	43	34.8	0	134	114	0	34	33	34
2025	10	14	5	50	30	27.9	-3.4	1.14	0.3	0.2	0	43.4	35.3	0	135	115	0	34	33	33
2025	10	14	6	0	30	28	-2.5	1.141	0.3	0.2	0	43	34.8	0	134	114	0	34	33	34
2025	10	14	6	10	30	27.5	-2.1	1.141	0.4	0.3	0	43	34.4	0	134	114	0	34	34	34
2025	10	14	6	20	30	27.8	-4	1.142	0.5	0.4	0	42.6	34.4	0	133	114	0	34	34	34
2025	10	14	6	30	30	28	-2.4	1.141	0.4	0.3	0	42.6	35.3	0	134	115	0	35	33	34
2025	10	14	6	40	30	27.6	-4	1.141	0.4	0.3	0	43	34.8	0	134	114	0	34	33	34
2025	10	14	6	50	30	27.9	-2.3	1.143	0.4	0.3	0	43	35.3	0	134	114	0	34	32	34
2025	10	14	7	0	30	27.7	-3.4	1.142	0.3	0.2	0	42.6	34.4	0	133	114	0	34	34	35
2025	10	14	7	10	30	28	-3.4	1.142	0.3	0.2	0	42.6	34.8	0	133	114	0	34	33	34
2025	10	14	7	20	30	26.8	-3.7	1.141	0.3	0.2	0	42.6	33.5	0	133	111	0	34	33	34
2025	10	14	7	30	30	27.1	-2.7	1.141	0.4	0.3	0	42.6	34.4	0	133	113	0	34	33	34
2025	10	14	7	40	30	26.6	-2.1	1.141	0.3	0.2	0	42.1	34.4	0	132	113	0	34	33	34
2025	10	14	7	50	30	26.8	-2.4	1.142	0.4	0.3	0	41.3	34	0	131	112	0	35	33	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	14	8	0	30	27.6	-2.2	1.143	0.4	0.3	0	41.7	34.4	0	132	113	0	35	33	34
2025	10	14	8	10	30	28.1	-2.4	1.143	0.4	0.3	0	42.6	34.4	0	133	113	0	34	33	34
2025	10	14	8	20	30	28.1	-2.7	1.141	0.5	0.4	0	43	34.8	0	135	114	0	35	33	35
2025	10	14	8	30	30	27.2	-2	1.142	0.3	0.2	0	42.6	34	0	133	113	0	34	34	34
2025	10	14	8	40	30	28	-3	1.142	0.4	0.3	0	43	34.8	0	134	114	0	34	33	34
2025	10	14	8	50	30	28.2	-2.6	1.144	0.4	0.3	0	42.6	35.3	0	134	115	0	35	33	34
2025	10	14	9	0	30	27.9	-3.4	1.144	0.3	0.2	0	42.6	34.8	0	134	114	0	35	33	34
2025	10	14	9	10	30	28	-2	1.145	0.3	0.2	0	43	34.4	0	134	114	0	34	34	34
2025	10	14	9	20	30	27.7	-2.6	1.145	0.3	0.2	0	43	35.3	0	134	115	0	34	33	34
2025	10	14	9	30	30	27.6	-2.2	1.146	0.3	0.2	0	43	35.3	0	135	115	0	35	33	34
2025	10	14	9	40	30	27.5	-1.8	1.147	0.3	0.2	0	43.4	35.3	0	135	115	0	34	33	35
2025	10	14	9	50	30	27.9	-2.5	1.147	0.3	0.2	0	43	35.3	0	135	115	0	35	33	33
2025	10	14	10	0	30	27.4	-2	1.147	0.3	0.2	0	43.4	35.7	0	136	116	0	35	33	34
2025	10	14	10	10	30	26.8	-2.1	1.148	0.4	0.3	0	43	34.8	0	135	115	0	35	34	33
2025	10	14	10	20	30	27.1	-1.7	1.148	0.4	0.3	0	43.4	35.3	0	135	115	0	34	33	34
2025	10	14	10	30	30	28.4	-2.1	1.149	0.3	0.2	0	43	34.8	0	134	114	0	34	33	33
2025	10	14	10	40	30	27.9	-2.6	1.149	0.3	0.2	0	43.4	34.8	0	135	115	0	34	34	34
2025	10	14	10	50	30	27.9	-3.1	1.15	0.3	0.2	0	43.4	35.7	0	136	116	0	35	33	34
2025	10	14	11	0	30	28.4	-2.1	1.15	0.5	0.4	0	43.4	35.7	0	136	116	0	35	33	34
2025	10	14	11	10	30	28.1	-2.5	1.151	0.3	0.2	0	43.4	36.1	0	136	117	0	35	33	34
2025	10	14	11	20	30	27.7	-3.8	1.151	0.3	0.2	0	43	35.7	0	135	116	0	35	33	34
2025	10	14	11	30	30	28.5	-2.6	1.151	0.3	0.2	0	43	35.3	0	134	115	0	34	33	34
2025	10	14	11	40	30	28	-3.1	1.152	0.3	0.2	0	43	34.4	0	134	114	0	34	34	33
2025	10	14	11	50	30	28.6	-3	1.153	0.3	0.2	0	43	35.3	0	134	115	0	34	33	34
2025	10	14	12	0	30	27.6	-2.5	1.152	0.5	0.4	0	43.4	35.3	0	135	115	0	34	33	33
2025	10	14	12	10	30	28.5	-2	1.153	0.3	0.2	0	43.4	35.3	0	135	116	0	34	34	34
2025	10	14	12	20	30	27.7	-3.1	1.154	0.3	0.2	0	43	35.7	0	135	116	0	35	33	34
2025	10	14	12	30	30	27.7	-2.1	1.156	0.3	0.2	0	42.6	35.3	0	134	115	0	35	33	34
2025	10	14	12	40	30	28	-2.8	1.158	0.4	0.3	0	43.9	35.7	0	136	116	0	34	33	34
2025	10	14	12	50	30	28.1	-2.9	1.159	0.4	0.3	0	44.7	37.4	0	138	120	0	34	33	34
2025	10	14	13	0	30	27.7	-2	1.16	0.4	0.3	0	43.4	36.1	0	136	117	0	35	33	34
2025	10	14	13	10	30	28.2	-1.8	1.161	0.3	0.2	0	43.9	35.7	0	136	117	0	34	34	34
2025	10	14	13	20	30	28.7	-2.1	1.161	0.3	0.2	0	43.9	36.5	0	136	118	0	34	33	34
2025	10	14	13	30	30	27.8	-2.1	1.162	0.4	0.3	0	43.9	36.1	0	136	117	0	34	33	34
2025	10	14	13	40	30	27.8	-1.9	1.161	0.4	0.3	0	43.4	34.8	0	135	115	0	34	34	34
2025	10	14	13	50	30	28.4	-2.4	1.162	0.3	0.2	0	43	34.8	0	134	115	0	34	34	34
2025	10	14	14	0	30	28.3	-1.8	1.162	0.4	0.3	0	43	35.3	0	134	115	0	34	33	34
2025	10	14	14	10	30	27.3	-1.4	1.163	0.4	0.3	0	43	34.8	0	134	115	0	34	34	34
2025	10	14	14	20	30	28.7	-1.8	1.164	0.4	0.3	0	43.4	35.3	0	135	116	0	34	34	33
2025	10	14	14	30	30	28	-2	1.163	0.3	0.2	0	43.9	35.3	0	136	116	0	34	34	34
2025	10	14	14	40	30	27.7	-2	1.163	0.4	0.3	0	44.3	35.7	0	137	117	0	34	34	34
2025	10	14	14	50	30	27	-1.3	1.165	0.3	0.2	0	44.3	36.1	0	137	117	0	34	33	33
2025	10	14	15	0	30	27.1	-1.7	1.166	0.4	0.3	0	44.3	36.1	0	137	117	0	34	33	34
2025	10	14	15	10	30	27.5	-1.5	1.165	0.3	0.2	0	43.4	36.1	0	136	117	0	35	33	34
2025	10	14	15	20	30	27.8	-3.1	1.164	0.4	0.3	0	43.9	36.1	0	136	117	0	34	33	34
2025	10	14	15	30	30	28.3	-2.1	1.166	0.4	0.3	0	43.9	35.7	0	136	116	0	34	33	34
2025	10	14	15	40	30	28.2	-2.2	1.165	0.4	0.3	0	43.4	35.7	0	135	116	0	34	33	34
2025	10	14	15	50	30	28.2	-1.9	1.166	0.3	0.2	0	43.4	34.8	0	135	115	0	34	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	14	16	0	30	28.1	-3	1.167	0.3	0.2	0	43.4	35.3	0	135	115	0	34	33	34
2025	10	14	16	10	30	27.2	-1.5	1.168	0.3	0.2	0	43.4	35.7	0	136	116	0	35	33	35
2025	10	14	16	20	30	28.3	-2.1	1.167	0.4	0.3	0	43.9	35.7	0	136	116	0	34	33	34
2025	10	14	16	30	30	27.5	-1.2	1.168	0.3	0.2	0	43.9	35.7	0	136	116	0	34	33	34
2025	10	14	16	40	30	28.1	-2.5	1.168	0.3	0.2	0	43.9	35.3	0	136	116	0	34	34	34
2025	10	14	16	50	30	28.7	-3	1.167	0.3	0.2	0	43	35.3	0	135	116	0	35	34	35
2025	10	14	17	0	30	29	-2.5	1.167	0.3	0.2	0	43.9	35.7	0	136	116	0	34	33	34
2025	10	14	17	10	30	28.1	-2.6	1.168	0.5	0.4	0	43.4	34.8	0	135	115	0	34	34	34
2025	10	14	17	20	30	28.8	-3.1	1.167	0.3	0.2	0	43	34.8	0	134	114	0	34	33	34
2025	10	14	17	30	30	27.8	-3.4	1.167	0.4	0.3	0	42.6	35.3	0	134	115	0	35	33	34
2025	10	14	17	40	30	28	-2.6	1.169	0.4	0.3	0	43	34.8	0	134	114	0	34	33	34
2025	10	14	17	50	30	28.3	-1.5	1.168	0.3	0.2	0	43	35.3	0	135	115	0	35	33	34
2025	10	14	18	0	30	28.5	-2	1.169	0.4	0.3	0	43	35.3	0	135	115	0	35	33	34
2025	10	14	18	10	30	27.6	-2.7	1.168	0.3	0.2	0	42.6	34.4	0	134	114	0	35	34	34
2025	10	14	18	20	30	28.9	-3.4	1.168	0.5	0.4	0	43.4	35.3	0	135	115	0	34	33	34
2025	10	14	18	30	30	28.2	-2.9	1.169	0.3	0.2	0	43	34.4	0	134	114	0	34	34	35
2025	10	14	18	40	30	27.5	-2.6	1.167	0.4	0.3	0	42.6	34.4	0	134	114	0	35	34	34
2025	10	14	18	50	30	28.3	-1.3	1.168	0.5	0.4	0	42.6	34.8	0	134	114	0	35	33	34
2025	10	14	19	0	30	27.9	-3.2	1.168	0.3	0.2	0	43	34.8	0	134	115	0	34	34	34
2025	10	14	19	10	30	27.6	-2.1	1.168	0.5	0.4	0	42.6	34.8	0	134	115	0	35	34	35
2025	10	14	19	20	30	28.5	-2.9	1.169	0.3	0.2	0	43.4	35.3	0	136	116	0	35	34	34
2025	10	14	19	30	30	28.4	-2.9	1.167	0.3	0.2	0	43	35.3	0	135	115	0	35	33	34
2025	10	14	19	40	30	28.6	-1.2	1.168	0.3	0.2	0	43	35.3	0	135	116	0	35	34	34
2025	10	14	19	50	30	28.4	-2.9	1.168	0.3	0.2	0	43	35.3	0	135	115	0	35	33	33
2025	10	14	20	0	30	28.7	-2	1.168	0.3	0.2	0	43	35.3	0	134	115	0	34	33	34
2025	10	14	20	10	30	28.4	-2.6	1.168	0.3	0.2	0	42.6	35.3	0	134	115	0	35	33	34
2025	10	14	20	20	30	28	-1.7	1.168	0.3	0.2	0	43.4	34.4	0	135	114	0	34	34	34
2025	10	14	20	30	30	28.1	-2.6	1.168	0.4	0.3	0	43.4	34.8	0	135	114	0	34	33	35
2025	10	14	20	40	30	29.2	-2.6	1.169	0.3	0.2	0	43.4	34.8	0	135	114	0	34	33	35
2025	10	14	20	50	30	29.3	-2.3	1.169	0.4	0.3	0	43.4	34.4	0	135	113	0	34	33	34
2025	10	14	21	0	30	28.9	-2.7	1.169	0.4	0.3	0	43	34	0	135	113	0	35	34	34
2025	10	14	21	10	30	28.4	-3.2	1.169	0.3	0.2	0	43	34	0	135	113	0	35	34	35
2025	10	14	21	20	30	28	-3.2	1.169	0.3	0.2	0	42.6	34.4	0	134	113	0	35	33	34
2025	10	14	21	30	30	28	-2.5	1.168	0.5	0.4	0	43.4	34	0	135	113	0	34	34	34
2025	10	14	21	40	30	28.4	-2.5	1.169	0.3	0.2	0	42.6	33.5	0	134	112	0	35	34	34
2025	10	14	21	50	30	28.5	-2.7	1.168	0.3	0.2	0	42.6	34.4	0	134	113	0	35	33	34
2025	10	14	22	0	30	29.4	-2.3	1.168	0.3	0.2	0	43	34.4	0	134	113	0	34	33	34
2025	10	14	22	10	30	29.2	-3.3	1.168	0.3	0.2	0	42.6	34.4	0	134	113	0	35	33	34
2025	10	14	22	20	30	29.5	-4.1	1.168	0.3	0.2	0	42.1	33.5	0	133	112	0	35	34	35
2025	10	14	22	30	30	28.5	-2.2	1.169	0.5	0.4	0	42.6	34	0	134	112	0	35	33	35
2025	10	14	22	40	30	28.2	-3.3	1.168	0.3	0.2	0	42.6	34	0	133	112	0	34	33	34
2025	10	14	22	50	30	27.9	-2.1	1.168	0.4	0.3	0	42.6	34	0	134	112	0	35	33	34
2025	10	14	23	0	30	27.9	-2.2	1.168	0.3	0.2	0	43	33.5	0	134	112	0	34	34	34
2025	10	14	23	10	30	28.2	-2.2	1.168	0.3	0.2	0	42.1	33.5	0	133	112	0	35	34	34
2025	10	14	23	20	30	29	-2.9	1.168	0.5	0.4	0	42.1	34	0	133	112	0	35	33	34
2025	10	14	23	30	30	29.6	-2.3	1.168	0.4	0.3	0	42.6	34	0	133	112	0	34	33	35
2025	10	14	23	40	30	28.2	-1.7	1.168	0.4	0.3	0	42.1	34	0	133	112	0	35	33	34
2025	10	14	23	50	30	28.7	-2.9	1.168	0.3	0.2	0	41.7	33.5	0	132	111	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	15	0	0	30	28	-2.8	1.169	0.3	0.2	0	42.6	33.5	0	133	111	0	34	33	34
2025	10	15	0	10	30	28.6	-2.9	1.169	0.3	0.2	0	41.7	33.1	0	132	111	0	35	34	34
2025	10	15	0	20	30	29.2	-2.8	1.168	0.3	0.2	0	42.1	33.5	0	132	111	0	34	33	34
2025	10	15	0	30	30	28.8	-2.9	1.168	0.3	0.2	0	41.7	33.5	0	132	111	0	35	33	34
2025	10	15	0	40	30	29.6	-3.8	1.168	0.4	0.3	0	42.1	33.5	0	132	111	0	34	33	34
2025	10	15	0	50	30	28.1	-2.9	1.168	0.3	0.2	0	42.1	33.5	0	132	111	0	34	33	34
2025	10	15	1	0	30	28	-3.5	1.168	0.3	0.2	0	42.1	33.5	0	132	111	0	34	33	35
2025	10	15	1	10	30	28.8	-2.6	1.168	0.3	0.2	0	41.7	33.5	0	132	111	0	35	33	34
2025	10	15	1	20	30	29.4	-3.9	1.168	0.5	0.4	0	42.1	33.1	0	132	111	0	34	34	34
2025	10	15	1	30	30	28.9	-3.1	1.168	0.4	0.3	0	41.7	33.1	0	132	111	0	35	34	34
2025	10	15	1	40	30	30.3	-4.4	1.168	0.3	0.2	0	41.7	33.1	0	132	111	0	35	34	34
2025	10	15	1	50	30	30.1	-2.7	1.168	0.4	0.3	0	41.7	33.5	0	132	111	0	35	33	34
2025	10	15	2	0	30	28.7	-2.9	1.168	0.3	0.2	0	42.1	33.1	0	132	111	0	34	34	33
2025	10	15	2	10	30	28	-3.2	1.168	0.3	0.2	0	42.6	34.4	0	134	113	0	35	33	34
2025	10	15	2	20	30	28	-1.9	1.168	0.3	0.2	0	42.6	33.5	0	133	112	0	34	34	34
2025	10	15	2	30	30	29.1	-2.5	1.168	0.3	0.2	0	43.9	35.3	0	137	116	0	35	34	34
2025	10	15	2	40	30	29.1	-3.7	1.168	0.3	0.2	0	41.7	33.1	0	131	110	0	34	33	34
2025	10	15	2	50	30	29.6	-3.8	1.168	0.4	0.3	0	42.1	34	0	133	112	0	35	33	34
2025	10	15	3	0	30	29.1	-3.5	1.168	0.3	0.2	0	41.3	33.1	0	131	110	0	35	33	34
2025	10	15	3	10	30	28.7	-3.3	1.168	0.4	0.3	0	41.7	33.1	0	131	110	0	34	33	35
2025	10	15	3	20	30	28.9	-2.8	1.168	0.3	0.2	0	41.7	33.1	0	132	111	0	35	34	35
2025	10	15	3	30	30	28.4	-3.6	1.168	0.4	0.3	0	41.3	32.7	0	131	110	0	35	34	35
2025	10	15	3	40	30	29.1	-2.8	1.168	0.5	0.4	0	41.7	33.1	0	132	111	0	35	34	35
2025	10	15	3	50	30	28.5	-3	1.168	0.4	0.3	0	42.1	33.1	0	132	111	0	34	34	34
2025	10	15	4	0	30	27	-2.9	1.168	0.4	0.3	0	42.1	33.1	0	133	111	0	35	34	34
2025	10	15	4	10	30	28.3	-2.5	1.168	0.4	0.3	0	41.7	33.1	0	132	111	0	35	34	34
2025	10	15	4	20	30	27.6	-2.8	1.168	0.3	0.2	0	42.1	33.5	0	133	111	0	35	33	34
2025	10	15	4	30	30	29	-3.5	1.168	0.3	0.2	0	41.7	32.7	0	131	110	0	34	34	34
2025	10	15	4	40	30	28.6	-3.6	1.168	0.3	0.2	0	42.6	34	0	134	113	0	35	34	35
2025	10	15	4	50	30	28.8	-2.4	1.168	0.5	0.5	0	41.7	32.7	0	132	110	0	35	34	34
2025	10	15	5	0	30	29.2	-3.3	1.168	0.4	0.3	0	41.3	32.7	0	131	109	0	35	33	34
2025	10	15	5	10	30	27.2	-3.5	1.168	0.5	0.4	0	41.3	33.1	0	131	110	0	35	33	35
2025	10	15	5	20	30	28.3	-3.3	1.168	0.4	0.3	0	40.9	32.3	0	130	109	0	35	34	34
2025	10	15	5	30	30	29	-3.2	1.168	0.4	0.3	0	41.3	32.3	0	130	109	0	34	34	34
2025	10	15	5	40	30	29.3	-2.7	1.168	0.4	0.3	0	40.9	32.3	0	130	109	0	35	34	35
2025	10	15	5	50	30	28.5	-2.2	1.167	0.4	0.3	0	40.9	32.7	0	130	109	0	35	33	35
2025	10	15	6	0	30	28.6	-2.2	1.167	0.3	0.2	0	40.9	32.7	0	130	109	0	35	33	34
2025	10	15	6	10	30	27.8	-1.6	1.167	0.3	0.2	0	40.9	32.7	0	130	109	0	35	33	35
2025	10	15	6	20	30	29.2	-2.9	1.167	0.4	0.3	0	41.3	31.8	0	130	108	0	34	34	35
2025	10	15	6	30	30	29.4	-2.8	1.167	0.3	0.2	0	40.9	31.8	0	129	108	0	34	34	34
2025	10	15	6	40	30	28.9	-2.8	1.167	0.3	0.2	0	40.4	31.8	0	129	108	0	35	34	35
2025	10	15	6	50	30	29	-3.9	1.167	0.4	0.3	0	40.9	31.4	0	129	107	0	34	34	34
2025	10	15	7	0	30	29.4	-2.9	1.167	0.5	0.4	0	40.4	32.3	0	129	108	0	35	33	35
2025	10	15	7	10	30	28.1	-2.9	1.167	0.4	0.3	0	40.4	31.8	0	129	108	0	35	34	34
2025	10	15	7	20	30	30.3	-3.2	1.167	0.3	0.2	0	39.6	31.4	0	127	106	0	35	33	34
2025	10	15	7	30	30	28.2	-2.8	1.167	0.4	0.3	0	39.6	31.4	0	127	106	0	35	33	34
2025	10	15	7	40	30	29	-2.5	1.167	0.4	0.3	0	40	31.8	0	127	106	0	34	32	34
2025	10	15	7	50	30	28.3	-3.7	1.167	0.5	0.4	0	39.1	31	0	126	105	0	35	33	34

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	10	15	8	0	30	29.8	-3.7	1.167	0.3	0.2	0	39.1	30.5	0	126	105	0	35	34	34	
2025	10	15	8	10	30	28.3	-3.3	1.167	0.3	0.2	0	38.7	30.5	0	125	105	0	35	34	35	
2025	10	15	8	20	30	28.4	-2.9	1.167	0.4	0.3	0	38.7	30.5	0	125	105	0	35	34	35	
2025	10	15	8	30	30	29.2	-3.1	1.167	0.4	0.3	0	39.1	30.5	0	126	105	0	35	34	35	
2025	10	15	8	40	30	27.3	-3.8	1.167	0.4	0.3	0	38.7	31	0	125	105	0	35	33	34	
2025	10	15	8	50	30	29.6	-2.5	1.167	0.3	0.2	0	39.1	31	0	125	105	0	34	33	35	
2025	10	15	9	0	30	28.2	-2.5	1.167	0.3	0.2	0	38.7	30.1	0	125	104	0	35	34	35	
2025	10	15	9	10	30	27.8	-3.2	1.167	0.4	0.3	0	38.3	30.5	0	124	104	0	35	33	35	
2025	10	15	9	20	30	27.9	-2.9	1.167	0.4	0.3	0	38.3	30.1	0	124	104	0	35	34	34	
2025	10	15	9	30	30	29.1	-2.5	1.167	0.3	0.2	0	38.3	30.1	0	124	104	0	35	34	34	
2025	10	15	9	40	30	28.2	-3.1	1.167	0.3	0.2	0	37.8	30.1	0	123	103	0	35	33	35	
2025	10	15	9	50	30	27.7	-3.3	1.167	0.3	0.2	0	38.3	30.1	0	124	104	0	35	34	34	
2025	10	15	10	2	15	28.2	-3.2	1.167	0.4	0.3	0	37.8	30.1	0	123	103	0	35	33	34	
2025	10	15	10	12	15	27.8	-2.8	1.167	0.4	0.3	0	38.3	30.5	0	124	104	0	35	33	34	
2025	10	15	10	22	15	27.8	-3.3	1.167	0.3	0.2	0	38.3	30.5	0	124	104	0	35	33	34	
2025	10	15	10	32	15	30.1	-2.8	1.167	0.3	0.2	0	37.8	30.1	0	123	103	0	35	33	34	
2025	10	15	10	42	15	28.4	-2.8	1.167	0.4	0.3	0	37.8	30.1	0	123	104	0	35	34	34	
2025	10	15	10	52	15	29.1	-2.7	1.167	0.3	0.2	0	37.8	29.7	0	123	103	0	35	34	34	
2025	10	15	11	2	15	27.7	-2.1	1.168	0.3	0.2	0	37.8	30.1	0	123	104	0	35	34	34	
2025	10	15	11	12	15	27.4	-2.9	1.168	0.3	0.2	0	37.8	30.5	0	123	104	0	35	33	35	
2025	10	15	11	22	15	27.9	-3.1	1.167	0.3	0.2	0	37.8	30.1	0	123	103	0	35	33	35	
2025	10	15	11	32	15	27	-3.3	1.167	0.3	0.2	0	38.3	31	0	124	105	0	35	33	34	
2025	10	15	11	42	15	27.9	-2	1.167	0.3	0.2	0	37.8	30.1	0	123	104	0	35	34	35	
2025	10	15	11	52	15	28.2	-2.9	1.168	0.3	0.2	0	38.7	30.5	0	125	105	0	35	34	34	
2025	10	15	12	2	15	28.2	-3.2	1.167	0.3	0.2	0	37.8	30.5	0	123	104	0	35	33	34	
2025	10	15	12	12	15	27.9	-2.8	1.167	0.3	0.2	0	37.8	30.5	0	123	104	0	35	33	34	
2025	10	15	12	22	15	28.4	-3.3	1.167	0.3	0.2	0	37.8	29.7	0	123	103	0	35	34	35	
2025	10	15	12	32	15	28.7	-3.3	1.167	0.3	0.2	0	37.4	30.5	0	122	104	0	35	33	35	
2025	10	15	12	42	15	28.5	-2.9	1.167	0.3	0.2	0	37.8	30.5	0	123	105	0	35	34	34	
2025	10	15	12	52	15	28.3	-3.1	1.167	0.4	0.3	0	37.8	29.7	0	123	103	0	35	34	35	
2025	10	15	13	2	15	29.9	-4.4	1.167	0.3	0.2	0	37.8	30.1	0	123	103	0	35	33	35	
2025	10	15	13	12	15	28.7	-3.1	1.167	0.4	0.3	0	38.7	30.5	0	124	104	0	34	33	34	
2025	10	15	13	22	15	29.3	-1.9	1.167	0.3	0.2	0	38.3	31	0	124	105	0	35	33	35	
2025	10	15	13	32	15	27.6	-3.1	1.167	0.3	0.2	0	38.3	30.5	0	124	104	0	35	33	35	
2025	10	15	13	42	15	28.4	-2.8	1.167	0.3	0.2	0	38.7	30.5	0	125	105	0	35	34	35	
2025	10	15	13	52	15	28.3	-2.9	1.167	0.3	0.2	0	39.1	31	0	126	106	0	35	34	34	
2025	10	15	14	2	15	28.1	-2.1	1.167	0.4	0.3	0	38.7	30.1	0	124	104	0	34	34	35	
2025	10	15	14	12	15	28.5	-2.7	1.167	0.3	0.2	0	37	29.7	0	122	102	0	36	33	34	
2025	10	15	14	22	15	28.7	-3	1.167	0.3	0.2	0	37	29.7	0	121	102	0	35	33	35	
2025	10	15	14	32	15	28.3	-2.1	1.167	0.3	0.2	0	37.4	29.2	0	122	102	0	35	34	34	
2025	10	15	14	42	15	28.3	-3.1	1.167	0.4	0.3	0	37	29.7	0	121	102	0	35	33	34	
2025	10	15	14	52	15	27.7	-3.2	1.166	0.4	0.3	0	37.4	29.7	0	122	102	0	35	33	34	
2025	10	15	15	2	15	28	-2.9	1.166	0.4	0.3	0	37.4	30.1	0	122	103	0	35	33	34	
2025	10	15	15	12	15	27.8	-2.1	1.166	0.3	0.2	0	37.8	30.1	0	122	103	0	34	33	34	
2025	10	15	15	22	15	28.3	-2.9	1.166	0.4	0.3	0	38.3	29.7	0	123	103	0	34	34	34	
2025	10	15	15	32	15	28.5	-2.4	1.166	0.3	0.2	0	37.8	29.7	0	123	103	0	35	34	34	
2025	10	15	15	42	15	28.5	-1.6	1.166	0.3	0.2	0	37.8	30.5	0	123	104	0	35	33	34	
2025	10	15	15	52	15	29.2	-2.9	1.166	0.3	0.2	0	38.7	31	0	124	105	0	34	33	34	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	15	16	2	15	28	-1.7	1.166	0.3	0.2	0	38.7	30.5	0	125	105	0	35	34	33
2025	10	15	16	12	15	28.9	-3.6	1.166	0.3	0.2	0	38.7	30.5	0	124	105	0	34	34	34
2025	10	15	16	22	15	28.3	-3.4	1.166	0.3	0.2	0	38.3	30.5	0	124	104	0	35	33	34
2025	10	15	16	32	15	29.1	-3.1	1.166	0.3	0.2	0	38.3	30.5	0	124	104	0	35	33	34
2025	10	15	16	42	15	29.6	-3.5	1.166	0.3	0.2	0	38.3	30.1	0	124	104	0	35	34	34
2025	10	15	16	52	15	28	-2.8	1.165	0.4	0.3	0	38.7	30.5	0	125	105	0	35	34	35
2025	10	15	17	2	15	28.4	-2.6	1.165	0.3	0.2	0	38.7	30.5	0	125	105	0	35	34	34
2025	10	15	17	12	15	28.8	-2.3	1.166	0.3	0.2	0	39.1	30.5	0	125	105	0	34	34	34
2025	10	15	17	22	15	27.4	-2.5	1.165	0.3	0.2	0	38.7	31	0	125	105	0	35	33	34
2025	10	15	17	32	15	28	-3.7	1.165	0.3	0.2	0	39.1	31.4	0	126	106	0	35	33	34
2025	10	15	17	42	15	27.9	-3.5	1.166	0.3	0.2	0	39.1	31	0	126	105	0	35	33	34
2025	10	15	17	52	15	28.6	-2.6	1.165	0.3	0.2	0	39.6	31	0	127	106	0	35	34	34
2025	10	15	18	2	15	29.3	-3.3	1.165	0.3	0.2	0	39.1	31.4	0	126	106	0	35	33	35
2025	10	15	18	12	15	28.1	-3.6	1.165	0.3	0.2	0	39.6	31.4	0	127	107	0	35	34	34
2025	10	15	18	22	15	28.4	-3.6	1.165	0.4	0.3	0	39.6	31.8	0	127	107	0	35	33	34
2025	10	15	18	32	15	29	-3	1.165	0.3	0.2	0	40	32.3	0	128	108	0	35	33	34
2025	10	15	18	42	15	28.7	-3	1.165	0.4	0.3	0	40.4	32.7	0	129	109	0	35	33	34
2025	10	15	18	52	15	28.4	-2.1	1.165	0.4	0.3	0	41.3	33.5	0	131	111	0	35	33	34
2025	10	15	19	2	15	29.1	-2.5	1.165	0.4	0.3	0	40.9	32.7	0	130	110	0	35	34	34
2025	10	15	19	12	15	28.1	-3.4	1.165	0.4	0.3	0	41.7	33.1	0	131	110	0	34	33	34
2025	10	15	19	22	15	27.7	-2.7	1.165	0.4	0.3	0	41.3	33.5	0	131	111	0	35	33	34
2025	10	15	19	32	15	29.6	-3	1.165	0.3	0.2	0	41.3	33.1	0	131	111	0	35	34	34
2025	10	15	19	42	15	28.3	-4.1	1.165	0.4	0.3	0	42.1	33.1	0	132	111	0	34	34	35
2025	10	15	19	52	15	29.1	-2.1	1.165	0.3	0.2	0	41.7	33.1	0	132	111	0	35	34	35
2025	10	15	20	2	15	28.3	-3.3	1.165	0.3	0.2	0	41.3	33.1	0	131	111	0	35	34	34
2025	10	15	20	12	15	30.1	-4	1.165	0.4	0.3	0	42.1	33.1	0	132	111	0	34	34	34
2025	10	15	20	22	15	28.7	-3.3	1.165	0.3	0.2	0	42.1	33.1	0	133	111	0	35	34	35
2025	10	15	20	32	15	29.2	-2.9	1.165	0.4	0.3	0	42.1	33.5	0	132	112	0	34	34	34
2025	10	15	20	42	15	28.9	-2.3	1.165	0.3	0.2	0	42.6	33.5	0	133	112	0	34	34	34
2025	10	15	20	52	15	29.4	-2.8	1.165	0.3	0.2	0	42.1	34	0	133	112	0	35	33	34
2025	10	15	21	2	15	29.8	-2.8	1.165	0.3	0.2	0	42.1	33.5	0	133	112	0	35	34	34
2025	10	15	21	12	15	28.8	-4.3	1.165	0.4	0.3	0	42.1	33.5	0	132	111	0	34	33	34
2025	10	15	21	22	15	30.3	-3.2	1.165	0.5	0.4	0	41.7	33.5	0	132	112	0	35	34	35
2025	10	15	21	32	15	28.2	-2.5	1.165	0.3	0.2	0	42.1	33.5	0	132	112	0	34	34	34
2025	10	15	21	42	15	29.5	-2.9	1.165	0.4	0.3	0	41.7	33.1	0	132	111	0	35	34	34
2025	10	15	21	52	15	28.2	-2.5	1.165	0.3	0.2	0	42.1	33.1	0	132	111	0	34	34	35
2025	10	15	22	2	15	29.5	-1.9	1.165	0.4	0.3	0	42.1	33.5	0	133	112	0	35	34	34
2025	10	15	22	12	15	28.6	-2.5	1.165	0.4	0.3	0	42.1	33.5	0	133	111	0	35	33	35
2025	10	15	22	22	15	28.9	-2.5	1.165	0.3	0.2	0	42.1	33.5	0	133	111	0	35	33	34
2025	10	15	22	32	15	29.4	-2.8	1.165	0.3	0.2	0	42.6	33.5	0	133	111	0	34	33	34
2025	10	15	22	42	15	28.6	-2.3	1.165	0.4	0.3	0	42.1	33.5	0	133	111	0	35	33	34
2025	10	15	22	52	15	28.5	-2.5	1.165	0.3	0.2	0	42.1	33.1	0	133	111	0	35	34	35
2025	10	15	23	2	15	29	-2.9	1.165	0.4	0.3	0	42.1	33.5	0	133	111	0	35	33	34
2025	10	15	23	12	15	27.4	-3	1.165	0.4	0.3	0	42.6	33.1	0	133	111	0	34	34	34
2025	10	15	23	22	15	28.6	-2.9	1.165	0.4	0.3	0	42.6	33.1	0	133	111	0	34	34	35
2025	10	15	23	32	15	29	-3	1.165	0.5	0.4	0	42.1	33.1	0	133	111	0	35	34	34
2025	10	15	23	42	15	29.9	-3.5	1.164	0.3	0.2	0	42.1	33.1	0	133	111	0	35	34	34
2025	10	15	23	52	15	28.1	-2.3	1.165	0.4	0.3	0	42.1	33.5	0	133	111	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	16	0	2	15	27.8	-2.8	1.165	0.4	0.3	0	42.6	33.5	0	133	111	0	34	33	34
2025	10	16	0	12	15	28.2	-2.1	1.165	0.3	0.2	0	42.6	33.1	0	133	111	0	34	34	34
2025	10	16	0	22	15	29.5	-3.4	1.165	0.5	0.4	0	42.1	33.1	0	133	111	0	35	34	34
2025	10	16	0	32	15	28.2	-2.5	1.165	0.4	0.3	0	42.1	33.1	0	133	110	0	35	33	34
2025	10	16	0	42	15	29.2	-3.3	1.165	0.3	0.2	0	42.1	33.1	0	133	111	0	35	34	35
2025	10	16	0	52	15	28.7	-2.6	1.165	0.3	0.2	0	42.6	33.5	0	134	112	0	35	34	34
2025	10	16	1	2	15	27.9	-2	1.165	0.3	0.2	0	42.1	33.5	0	132	111	0	34	33	34
2025	10	16	1	12	15	28.3	-2.7	1.165	0.4	0.3	0	41.7	33.5	0	132	111	0	35	33	34
2025	10	16	1	22	15	28	-2.1	1.165	0.3	0.2	0	42.1	32.7	0	132	110	0	34	34	35
2025	10	16	1	32	15	27.1	-2.5	1.165	0.3	0.2	0	42.1	33.5	0	132	111	0	34	33	35
2025	10	16	1	42	15	28.8	-1.7	1.165	0.4	0.3	0	41.7	32.7	0	132	110	0	35	34	34
2025	10	16	1	52	15	28.3	-2.7	1.165	0.5	0.4	0	42.1	33.5	0	132	111	0	34	33	35
2025	10	16	2	2	15	27.9	-2.9	1.165	0.5	0.4	0	40.9	30.5	0	130	104	0	35	33	34
2025	10	16	2	12	15	29.8	-3.6	1.165	0.3	0.2	0	42.1	32.7	0	132	110	0	34	34	34
2025	10	16	2	22	15	29.8	-2.7	1.165	0.5	0.4	0	41.3	33.1	0	131	110	0	35	33	35
2025	10	16	2	32	15	28.2	-3.1	1.165	0.3	0.2	0	41.7	33.1	0	131	110	0	34	33	34
2025	10	16	2	42	15	29	-3.1	1.165	0.5	0.4	0	41.7	33.1	0	131	110	0	34	33	34
2025	10	16	2	52	15	29.1	-3.3	1.165	0.5	0.4	0	41.3	32.7	0	131	110	0	35	34	35
2025	10	16	3	2	15	29.1	-2.5	1.165	0.3	0.2	0	41.7	32.7	0	132	110	0	35	34	34
2025	10	16	3	12	15	29.2	-2.3	1.165	0.4	0.3	0	41.3	32.3	0	131	109	0	35	34	34
2025	10	16	3	22	15	27.3	-2	1.165	0.3	0.2	0	41.7	32.7	0	132	110	0	35	34	35
2025	10	16	3	32	15	27.8	-3.3	1.165	0.3	0.2	0	41.7	32.7	0	132	110	0	35	34	34
2025	10	16	3	42	15	28.7	-4.4	1.165	0.5	0.4	0	41.3	33.1	0	131	110	0	35	33	34
2025	10	16	3	52	15	28.2	-3.3	1.165	0.4	0.3	0	41.3	32.7	0	131	110	0	35	34	34
2025	10	16	4	2	15	27.4	-2.6	1.165	0.4	0.3	0	41.7	32.7	0	131	110	0	34	34	35
2025	10	16	4	12	15	28.2	-1.9	1.165	0.5	0.4	0	41.3	33.1	0	131	110	0	35	33	35
2025	10	16	4	22	15	27.9	-1.8	1.165	0.3	0.2	0	41.3	33.1	0	131	110	0	35	33	34
2025	10	16	4	32	15	28.9	-2	1.165	0.5	0.4	0	41.3	32.7	0	131	109	0	35	33	35
2025	10	16	4	42	15	27.8	-2.9	1.165	0.3	0.2	0	41.3	32.7	0	131	110	0	35	34	35
2025	10	16	4	52	15	28.3	-1.7	1.165	0.3	0.2	0	41.3	33.1	0	131	110	0	35	33	34
2025	10	16	5	2	15	29.3	-2.8	1.165	0.3	0.2	0	41.3	32.3	0	131	109	0	35	34	34
2025	10	16	5	12	15	29	-3.1	1.165	0.5	0.4	0	41.7	32.7	0	131	110	0	34	34	34
2025	10	16	5	22	15	28.7	-3.6	1.165	0.3	0.2	0	40.9	32.3	0	130	109	0	35	34	34
2025	10	16	5	32	15	27.9	-2.3	1.165	0.3	0.2	0	41.7	32.3	0	131	109	0	34	34	34
2025	10	16	5	42	15	28.5	-2.5	1.165	0.3	0.2	0	41.3	33.1	0	131	110	0	35	33	35
2025	10	16	5	52	15	28.8	-1.6	1.165	0.4	0.3	0	41.3	32.3	0	130	109	0	34	34	34
2025	10	16	6	2	15	29.8	-3.1	1.165	0.3	0.2	0	41.3	32.3	0	130	109	0	34	34	34
2025	10	16	6	12	15	28.4	-3.4	1.165	0.3	0.2	0	40.9	32.3	0	130	109	0	35	34	34
2025	10	16	6	22	15	28.6	-2.8	1.165	0.3	0.2	0	41.3	32.7	0	130	109	0	34	33	34
2025	10	16	6	32	15	29.3	-1.4	1.165	0.3	0.2	0	41.3	32.3	0	130	109	0	34	34	34
2025	10	16	6	42	15	29.6	-2.5	1.165	0.3	0.2	0	40.9	32.3	0	130	109	0	35	34	34
2025	10	16	6	52	15	28.3	-2.9	1.165	0.3	0.2	0	41.3	31.8	0	130	108	0	34	34	34
2025	10	16	7	2	15	27.9	-2.6	1.165	0.3	0.2	0	40.9	31.8	0	129	107	0	34	33	35
2025	10	16	7	12	15	27.4	-2.7	1.165	0.5	0.4	0	40.4	31.4	0	129	107	0	35	34	34
2025	10	16	7	22	15	29	-3.1	1.165	0.3	0.2	0	40.4	31.4	0	128	106	0	34	33	35
2025	10	16	7	32	15	27.8	-2.1	1.165	0.3	0.2	0	39.6	31.4	0	127	106	0	35	33	34
2025	10	16	7	42	15	28.5	-1.7	1.165	0.3	0.2	0	39.6	31	0	127	106	0	35	34	34
2025	10	16	7	52	15	28.7	-2.7	1.165	0.3	0.2	0	39.6	31.4	0	127	106	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	16	8	2	15	29.2	-3.1	1.165	0.4	0.3	0	39.6	30.5	0	126	105	0	34	34	34
2025	10	16	8	12	15	28.2	-2.5	1.165	0.3	0.2	0	39.6	30.5	0	126	105	0	34	34	35
2025	10	16	8	22	15	27.8	-2.1	1.165	0.6	0.5	0	39.1	30.5	0	126	104	0	35	33	34
2025	10	16	8	32	15	29	-2.4	1.165	0.3	0.2	0	38.7	30.1	0	125	104	0	35	34	35
2025	10	16	8	42	15	27.4	-2.3	1.165	0.3	0.2	0	38.7	30.5	0	125	104	0	35	33	34
2025	10	16	8	52	15	28.4	-2.9	1.165	0.3	0.2	0	39.1	30.5	0	125	105	0	34	34	34
2025	10	16	9	2	15	27.4	-1.7	1.165	0.3	0.2	0	39.1	30.5	0	126	104	0	35	33	34
2025	10	16	9	12	15	28.8	-1.4	1.166	0.4	0.3	0	38.7	30.1	0	125	103	0	35	33	34
2025	10	16	9	22	15	28	-2.5	1.165	0.3	0.2	0	39.1	30.1	0	125	103	0	34	33	35
2025	10	16	9	32	15	28.4	-3.3	1.166	0.4	0.3	0	38.3	30.1	0	124	103	0	35	33	35
2025	10	16	9	42	15	28.6	-2.8	1.166	0.4	0.3	0	37.8	29.7	0	123	102	0	35	33	34
2025	10	16	9	52	15	28.3	-2.3	1.166	0.4	0.3	0	38.7	29.2	0	124	103	0	34	35	35
2025	10	16	10	2	15	28.2	-1.7	1.166	0.3	0.2	0	38.3	29.7	0	124	103	0	35	34	34
2025	10	16	10	12	15	28.4	-1.3	1.166	0.3	0.2	0	37.8	30.1	0	124	103	0	36	33	35
2025	10	16	10	22	15	28.3	-2.7	1.166	0.5	0.5	0	38.3	30.1	0	124	104	0	35	34	34
2025	10	16	10	32	15	29.1	-2.3	1.166	0.4	0.3	0	38.3	30.1	0	124	103	0	35	33	34
2025	10	16	10	42	15	29.1	-2.6	1.166	0.4	0.3	0	37.4	29.2	0	122	102	0	35	34	34
2025	10	16	10	52	15	28.5	-3.7	1.166	0.3	0.2	0	38.3	29.7	0	123	102	0	34	33	34
2025	10	16	11	2	15	28.7	-2.4	1.166	0.4	0.3	0	37.8	29.2	0	123	102	0	35	34	34
2025	10	16	11	12	15	28.4	-2.6	1.166	0.3	0.2	0	37.8	29.7	0	123	103	0	35	34	34
2025	10	16	11	22	15	27.7	-2.9	1.166	0.4	0.3	0	37.8	30.1	0	123	103	0	35	33	34
2025	10	16	11	32	15	27.4	-2.1	1.166	0.4	0.3	0	37.8	30.1	0	123	103	0	35	33	34
2025	10	16	11	42	15	28.3	-2.3	1.165	0.3	0.2	0	38.3	30.1	0	124	103	0	35	33	35
2025	10	16	11	52	15	28.3	-3.3	1.166	0.3	0.2	0	38.7	29.7	0	124	103	0	34	34	35
2025	10	16	12	2	15	28	-2.2	1.165	0.3	0.2	0	38.7	29.7	0	124	103	0	34	34	35
2025	10	16	12	12	15	28.2	-2.1	1.165	0.3	0.2	0	38.3	30.1	0	124	104	0	35	34	34
2025	10	16	12	22	15	27.3	-3.1	1.166	0.4	0.3	0	38.7	30.5	0	125	104	0	35	33	34
2025	10	16	12	32	15	27.6	-2.2	1.166	0.3	0.2	0	38.3	30.1	0	124	104	0	35	34	34
2025	10	16	12	42	15	28.1	-2.8	1.166	0.5	0.4	0	39.1	30.5	0	125	104	0	34	33	34
2025	10	16	12	52	15	27.6	-2.6	1.166	0.3	0.2	0	39.6	31	0	126	105	0	34	33	34
2025	10	16	13	2	15	27.4	-2.5	1.165	0.3	0.2	0	38.3	30.1	0	124	104	0	35	34	34
2025	10	16	13	12	15	27.2	-2.9	1.166	0.4	0.3	0	38.7	30.5	0	125	105	0	35	34	35
2025	10	16	13	22	15	27.6	-1.7	1.166	0.3	0.2	0	38.3	30.1	0	124	104	0	35	34	35
2025	10	16	13	32	15	27.7	-2.5	1.165	0.4	0.3	0	38.7	30.5	0	125	104	0	35	33	35
2025	10	16	13	42	15	28.7	-3.5	1.166	0.3	0.2	0	38.3	30.1	0	123	103	0	34	33	34
2025	10	16	13	52	15	28.4	-2.5	1.166	0.3	0.2	0	38.3	30.1	0	124	103	0	35	33	34
2025	10	16	14	2	15	28.1	-2.8	1.165	0.3	0.2	0	39.6	31.4	0	126	106	0	34	33	34
2025	10	16	14	12	15	28.2	-2.5	1.166	0.3	0.2	0	39.1	30.1	0	125	104	0	34	34	34
2025	10	16	14	22	15	28.6	-1.8	1.166	0.3	0.2	0	38.3	30.5	0	124	104	0	35	33	35
2025	10	16	14	32	15	29.2	-2.9	1.166	0.5	0.4	0	38.7	30.5	0	125	104	0	35	33	34
2025	10	16	14	42	15	28.1	-2	1.166	0.3	0.2	0	40.4	31.8	0	129	107	0	35	33	34
2025	10	16	14	52	15	28.1	-2.5	1.166	0.3	0.2	0	39.6	31.4	0	126	106	0	34	33	35
2025	10	16	15	2	15	28.7	-1.2	1.166	0.3	0.2	0	39.1	31	0	126	106	0	35	34	34
2025	10	16	15	12	15	29.1	-3.3	1.166	0.3	0.2	0	38.7	31	0	125	105	0	35	33	35
2025	10	16	15	22	15	29	-2	1.165	0.3	0.2	0	38.7	31	0	125	105	0	35	33	34
2025	10	16	15	32	15	28.4	-2.1	1.166	0.3	0.2	0	39.1	31	0	126	105	0	35	33	34
2025	10	16	15	42	15	27.9	-2.5	1.165	0.4	0.3	0	39.1	30.5	0	126	105	0	35	34	34
2025	10	16	15	52	15	26.6	-2.4	1.166	0.5	0.4	0	39.1	31	0	126	105	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	16	16	2	15	28.4	-2.1	1.166	0.3	0.2	0	39.1	30.5	0	126	105	0	35	34	34
2025	10	16	16	12	15	28.1	-2.5	1.166	0.3	0.2	0	39.1	31	0	126	105	0	35	33	34
2025	10	16	16	22	15	27.2	-2.3	1.166	0.4	0.3	0	39.1	31	0	126	105	0	35	33	34
2025	10	16	16	32	15	28.2	-3.2	1.166	0.3	0.2	0	38.7	31	0	125	105	0	35	33	34
2025	10	16	16	42	15	27.8	-2.3	1.166	0.4	0.3	0	38.7	30.1	0	125	104	0	35	34	35
2025	10	16	16	52	15	28	-2.7	1.166	0.4	0.3	0	39.1	30.5	0	125	104	0	34	33	35
2025	10	16	17	2	15	29.2	-2.6	1.166	0.3	0.2	0	39.1	30.5	0	126	105	0	35	34	34
2025	10	16	17	12	15	28.4	-3.1	1.166	0.4	0.3	0	39.6	30.5	0	126	104	0	34	33	34
2025	10	16	17	22	15	28.9	-1.3	1.166	0.3	0.2	0	39.6	31	0	126	105	0	34	33	34
2025	10	16	17	32	15	28.6	-1.8	1.166	0.3	0.2	0	39.6	30.5	0	126	105	0	34	34	34
2025	10	16	17	42	15	28.5	-2.5	1.166	0.4	0.3	0	39.1	30.5	0	126	104	0	35	33	35
2025	10	16	17	52	15	28.8	-2.9	1.166	0.3	0.2	0	39.6	30.5	0	126	104	0	34	33	34
2025	10	16	18	2	15	29.1	-2.9	1.166	0.3	0.2	0	39.1	30.1	0	126	104	0	35	34	35
2025	10	16	18	12	15	27.9	-3.7	1.166	0.4	0.3	0	40	31.4	0	127	106	0	34	33	34
2025	10	16	18	22	15	28.8	-2.2	1.166	0.3	0.2	0	40	31	0	127	105	0	34	33	34
2025	10	16	18	32	15	27.6	-2.8	1.166	0.4	0.3	0	40.4	31	0	128	106	0	34	34	34
2025	10	16	18	42	15	29.1	-3.5	1.166	0.3	0.2	0	40	31	0	128	106	0	35	34	34
2025	10	16	18	52	15	29.2	-2.8	1.166	0.5	0.4	0	40.4	31.8	0	129	107	0	35	33	35
2025	10	16	19	2	15	28.7	-3.3	1.166	0.3	0.2	0	41.3	32.3	0	130	108	0	34	33	34
2025	10	16	19	12	15	28.8	-3.3	1.166	0.4	0.3	0	41.3	32.7	0	130	109	0	34	33	34
2025	10	16	19	22	15	29.4	-4.8	1.166	0.4	0.3	0	41.3	32.7	0	130	109	0	34	33	34
2025	10	16	19	32	15	29.5	-3.1	1.166	0.3	0.2	0	40.9	32.3	0	130	109	0	35	34	35
2025	10	16	19	42	15	28.1	-1.8	1.166	0.3	0.2	0	41.7	32.3	0	131	109	0	34	34	34
2025	10	16	19	52	15	28.7	-3.7	1.166	0.3	0.2	0	41.3	32.7	0	131	109	0	35	33	35
2025	10	16	20	2	15	28.2	-2.2	1.166	0.3	0.2	0	41.3	32.3	0	131	109	0	35	34	35
2025	10	16	20	12	15	30.3	-3.3	1.166	0.3	0.2	0	41.3	32.3	0	131	109	0	35	34	34
2025	10	16	20	22	15	29.3	-2.5	1.166	0.3	0.2	0	41.3	33.1	0	131	110	0	35	33	35
2025	10	16	20	32	15	29.4	-3.4	1.166	0.4	0.3	0	41.3	32.7	0	131	109	0	35	33	34
2025	10	16	20	42	15	29	-2.8	1.167	0.4	0.3	0	41.3	32.3	0	131	109	0	35	34	34
2025	10	16	20	52	15	28.8	-4.1	1.167	0.4	0.3	0	41.3	32.3	0	131	109	0	35	34	34
2025	10	16	21	2	15	30.5	-3.4	1.166	0.4	0.3	0	41.7	32.3	0	131	109	0	34	34	35
2025	10	16	21	12	15	29.7	-2.4	1.167	0.3	0.2	0	41.7	32.3	0	131	109	0	34	34	34
2025	10	16	21	22	15	29.1	-3.3	1.167	0.3	0.2	0	41.3	32.7	0	131	110	0	35	34	34
2025	10	16	21	32	15	28.3	-4	1.167	0.3	0.2	0	41.7	32.7	0	131	109	0	34	33	35
2025	10	16	21	42	15	28.5	-3.3	1.167	0.3	0.2	0	41.3	32.3	0	131	109	0	35	34	34
2025	10	16	21	52	15	28.4	-3.6	1.167	0.3	0.2	0	41.3	32.7	0	131	109	0	35	33	34
2025	10	16	22	2	15	30.4	-3.2	1.167	0.3	0.2	0	41.3	32.3	0	130	109	0	34	34	34
2025	10	16	22	12	15	29	-2.9	1.167	0.5	0.4	0	41.3	32.3	0	131	109	0	35	34	34
2025	10	16	22	22	15	28.9	-2	1.167	0.4	0.3	0	41.7	32.7	0	131	109	0	34	33	34
2025	10	16	22	32	15	28.6	-2.3	1.167	0.4	0.3	0	41.7	32.3	0	131	109	0	34	34	34
2025	10	16	22	42	15	29.7	-3.6	1.167	0.3	0.2	0	41.3	32.3	0	131	109	0	35	34	35
2025	10	16	22	52	15	29.2	-3.3	1.167	0.4	0.3	0	41.7	32.3	0	131	109	0	34	34	34
2025	10	16	23	2	15	28.9	-2.9	1.167	0.3	0.2	0	40.9	32.3	0	130	108	0	35	33	35
2025	10	16	23	12	15	29.3	-3.2	1.167	0.3	0.2	0	40.9	32.3	0	130	109	0	35	34	35
2025	10	16	23	22	15	29.6	-2.8	1.167	0.3	0.2	0	41.3	32.3	0	130	109	0	34	34	34
2025	10	16	23	32	15	28.8	-3.5	1.167	0.4	0.3	0	41.3	31.8	0	130	108	0	34	34	34
2025	10	16	23	42	15	28.5	-2.4	1.167	0.3	0.2	0	41.3	32.3	0	131	109	0	35	34	34
2025	10	16	23	52	15	28.3	-3	1.167	0.4	0.3	0	41.7	32.7	0	131	109	0	34	33	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	17	0	2	15	29.7	-3.8	1.167	0.3	0.2	0	40.9	32.7	0	130	109	0	35	33	35
2025	10	17	0	12	15	29.6	-2.8	1.167	0.5	0.4	0	40.9	31.8	0	130	108	0	35	34	35
2025	10	17	0	22	15	28.6	-2.6	1.167	0.4	0.3	0	40.9	31.8	0	130	108	0	35	34	35
2025	10	17	0	32	15	27.8	-3.8	1.167	0.5	0.4	0	39.6	31.8	0	126	108	0	34	34	35
2025	10	17	0	42	15	29.8	-3.6	1.167	0.3	0.2	0	41.3	32.3	0	131	108	0	35	33	35
2025	10	17	0	52	15	28.8	-3.2	1.167	0.3	0.2	0	41.7	32.3	0	132	108	0	35	33	35
2025	10	17	1	2	15	29.2	-3.3	1.167	0.3	0.2	0	41.3	32.3	0	131	108	0	35	33	35
2025	10	17	1	12	15	28.4	-2	1.167	0.3	0.2	0	41.3	31.8	0	131	108	0	35	34	34
2025	10	17	1	22	15	29.1	-2.4	1.167	0.4	0.3	0	41.3	32.3	0	131	108	0	35	33	35
2025	10	17	1	32	15	29.1	-3.2	1.167	0.4	0.3	0	41.7	31.8	0	131	108	0	34	34	34
2025	10	17	1	42	15	28.8	-3	1.167	0.5	0.4	0	40.9	31.4	0	130	107	0	35	34	35
2025	10	17	1	52	15	29	-4.1	1.167	0.3	0.2	0	41.3	31.8	0	131	108	0	35	34	35
2025	10	17	2	2	15	27.8	-2.6	1.167	0.3	0.2	0	41.3	31.8	0	131	108	0	35	34	34
2025	10	17	2	12	15	28	-2.5	1.167	0.3	0.2	0	41.3	31.8	0	131	108	0	35	34	34
2025	10	17	2	22	15	28.7	-2.6	1.167	0.3	0.2	0	41.3	31.8	0	131	107	0	35	33	35
2025	10	17	2	32	15	29.3	-3.8	1.167	0.3	0.2	0	40.9	31.8	0	130	107	0	35	33	34
2025	10	17	2	42	15	28.5	-3.3	1.167	0.3	0.2	0	40.4	31.8	0	129	107	0	35	33	34
2025	10	17	2	52	15	28.6	-3.7	1.168	0.4	0.3	0	40.9	31.4	0	131	107	0	36	34	33
2025	10	17	3	2	15	28.6	-2.9	1.168	0.3	0.2	0	41.3	31.8	0	131	107	0	35	33	34
2025	10	17	3	12	15	28.9	-3.1	1.168	0.3	0.2	0	41.3	31.8	0	131	108	0	35	34	34
2025	10	17	3	22	15	27.7	-1.2	1.168	0.3	0.2	0	41.3	31.8	0	131	108	0	35	34	34
2025	10	17	3	32	15	28.6	-2.9	1.168	0.3	0.2	0	41.3	31.8	0	131	107	0	35	33	35
2025	10	17	3	42	15	28.5	-3	1.168	0.3	0.2	0	41.3	31.8	0	131	108	0	35	34	35
2025	10	17	3	52	15	28.9	-2.5	1.168	0.4	0.3	0	41.7	32.3	0	131	108	0	34	33	34
2025	10	17	4	2	15	28.6	-4.2	1.168	0.3	0.2	0	41.7	31.8	0	131	107	0	34	33	34
2025	10	17	4	12	15	28.8	-3	1.168	0.4	0.3	0	41.3	31.4	0	131	107	0	35	34	35
2025	10	17	4	22	15	28.8	-3.3	1.168	0.3	0.2	0	41.7	31.4	0	131	107	0	34	34	34
2025	10	17	4	32	15	28.8	-3.3	1.168	0.5	0.5	0	41.3	31.4	0	131	107	0	35	34	34
2025	10	17	4	42	15	29.1	-2.4	1.168	0.3	0.2	0	40.9	31.4	0	130	107	0	35	34	34
2025	10	17	4	52	15	29.4	-2.8	1.168	0.3	0.2	0	41.3	31.8	0	131	108	0	35	34	35
2025	10	17	5	2	15	27.9	-3.6	1.168	0.5	0.5	0	40.9	31.8	0	130	107	0	35	33	34
2025	10	17	5	12	15	28.8	-2.8	1.168	0.5	0.4	0	41.7	31.4	0	131	107	0	34	34	34
2025	10	17	5	22	15	27.8	-2.8	1.168	0.4	0.3	0	40.9	31.4	0	130	107	0	35	34	34
2025	10	17	5	32	15	29	-4	1.168	0.3	0.2	0	40.9	31.4	0	130	106	0	35	33	34
2025	10	17	5	42	15	28.1	-3.4	1.168	0.3	0.2	0	40.9	31	0	130	106	0	35	34	34
2025	10	17	5	52	15	28.3	-3.2	1.168	0.4	0.3	0	40.9	31.4	0	130	107	0	35	34	34
2025	10	17	6	2	15	29.6	-4.3	1.168	0.4	0.3	0	40.4	31.4	0	129	106	0	35	33	35
2025	10	17	6	12	15	28.2	-2.9	1.168	0.3	0.2	0	40.9	31.4	0	130	107	0	35	34	34
2025	10	17	6	22	15	28.5	-2.5	1.168	0.3	0.2	0	40.9	31	0	130	106	0	35	34	34
2025	10	17	6	32	15	28.8	-3.2	1.168	0.4	0.3	0	41.3	31	0	130	106	0	34	34	34
2025	10	17	6	42	15	28.1	-2.1	1.168	0.5	0.4	0	40.9	31	0	130	106	0	35	34	34
2025	10	17	6	52	15	28.7	-3.4	1.168	0.3	0.2	0	40.4	31	0	129	106	0	35	34	35
2025	10	17	7	2	15	30.3	-3.9	1.168	0.4	0.3	0	40.9	31	0	129	105	0	34	33	34
2025	10	17	7	12	15	28.7	-2.8	1.168	0.3	0.2	0	40.4	30.5	0	129	105	0	35	34	35
2025	10	17	7	22	15	27.8	-2.1	1.168	0.3	0.2	0	40	30.1	0	128	105	0	35	35	34
2025	10	17	7	32	15	28.5	-2.4	1.169	0.3	0.2	0	39.6	30.1	0	127	104	0	35	34	34
2025	10	17	7	42	15	28.5	-2.7	1.169	0.3	0.2	0	40	29.7	0	127	103	0	34	34	34
2025	10	17	7	52	15	29.1	-2.7	1.168	0.4	0.3	0	39.1	29.7	0	126	103	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	17	8	2	15	27.4	-2.4	1.169	0.3	0.2	0	40	31	0	128	105	0	35	33	34
2025	10	17	8	12	15	28.8	-2.2	1.169	0.3	0.2	0	39.1	29.7	0	126	103	0	35	34	34
2025	10	17	8	22	15	29	-2.7	1.169	0.3	0.2	0	39.6	31	0	128	106	0	36	34	35
2025	10	17	8	32	15	28.2	-2.2	1.169	0.4	0.3	0	39.1	29.7	0	126	103	0	35	34	35
2025	10	17	8	42	15	29	-2.8	1.169	0.3	0.2	0	39.1	29.7	0	125	102	0	34	33	34
2025	10	17	8	52	15	28.2	-2.7	1.169	0.3	0.2	0	38.3	28.8	0	124	101	0	35	34	35
2025	10	17	9	2	15	27.9	-2.8	1.169	0.3	0.2	0	38.7	29.2	0	125	102	0	35	34	35
2025	10	17	9	12	15	27.9	-3.1	1.169	0.4	0.3	0	38.3	29.2	0	124	102	0	35	34	34
2025	10	17	9	22	15	29.2	-2.3	1.17	0.3	0.2	0	38.3	28.8	0	124	101	0	35	34	34
2025	10	17	9	32	15	27	-2.1	1.17	0.3	0.2	0	38.7	29.7	0	124	102	0	34	33	35
2025	10	17	9	42	15	27.4	-2.1	1.17	0.3	0.2	0	42.6	33.5	0	134	111	0	35	33	34
2025	10	17	9	52	15	28.6	-2	1.17	0.4	0.3	0	38.7	29.7	0	125	103	0	35	34	34
2025	10	17	10	2	15	27.9	-2	1.17	0.3	0.2	0	38.7	29.2	0	124	102	0	34	34	34
2025	10	17	10	12	15	28	-2.1	1.17	0.3	0.2	0	38.3	29.2	0	124	102	0	35	34	35
2025	10	17	10	22	15	28.3	-2.8	1.17	0.4	0.3	0	38.3	29.7	0	124	102	0	35	33	35
2025	10	17	10	32	15	28.4	-2.6	1.17	0.3	0.2	0	38.7	29.2	0	124	102	0	34	34	35
2025	10	17	10	42	15	27.9	-2.7	1.171	0.4	0.3	0	38.7	30.1	0	125	103	0	35	33	34
2025	10	17	10	52	15	29.4	-3.1	1.17	0.3	0.2	0	38.7	29.7	0	124	102	0	34	33	34
2025	10	17	11	2	15	27.8	-2.1	1.171	0.4	0.3	0	38.3	29.7	0	124	102	0	35	33	35
2025	10	17	11	12	15	28.3	-3.3	1.17	0.3	0.2	0	38.3	29.7	0	124	102	0	35	33	34
2025	10	17	11	22	15	27.6	-2.8	1.17	0.3	0.2	0	38.7	29.2	0	124	102	0	34	34	34
2025	10	17	11	32	15	29	-2	1.171	0.4	0.3	0	38.7	30.1	0	125	103	0	35	33	34
2025	10	17	11	42	15	28.6	-2.3	1.171	0.3	0.2	0	38.3	29.7	0	124	102	0	35	33	34
2025	10	17	11	52	15	27.8	-1.8	1.171	0.4	0.3	0	37.8	29.2	0	124	102	0	36	34	35
2025	10	17	12	2	15	28.4	-2.3	1.171	0.3	0.2	0	38.3	29.2	0	124	101	0	35	33	34
2025	10	17	12	12	15	29	-2.7	1.171	0.3	0.2	0	38.3	29.7	0	124	102	0	35	33	34
2025	10	17	12	22	15	28.9	-3.9	1.171	0.3	0.2	0	38.3	29.2	0	124	102	0	35	34	34
2025	10	17	12	32	15	29.2	-2.4	1.171	0.3	0.2	0	38.3	29.2	0	124	102	0	35	34	34
2025	10	17	12	42	15	28.4	-2.9	1.171	0.4	0.3	0	38.7	29.7	0	125	102	0	35	33	35
2025	10	17	12	52	15	28.4	-1.3	1.171	0.5	0.4	0	39.1	30.5	0	126	104	0	35	33	34
2025	10	17	13	2	15	29.2	-2.9	1.171	0.4	0.3	0	38.7	30.5	0	125	103	0	35	32	35
2025	10	17	13	12	15	27.9	-2.9	1.171	0.3	0.2	0	39.1	29.7	0	125	103	0	34	34	34
2025	10	17	13	22	15	29	-2	1.171	0.5	0.4	0	38.7	29.2	0	124	102	0	34	34	35
2025	10	17	13	32	15	28.6	-2.5	1.172	0.4	0.3	0	38.7	30.1	0	125	103	0	35	33	34
2025	10	17	13	42	15	28.3	-2.1	1.171	0.4	0.3	0	38.7	29.7	0	125	103	0	35	34	34
2025	10	17	13	52	15	28.7	-2.7	1.171	0.3	0.2	0	38.7	29.7	0	125	102	0	35	33	34
2025	10	17	14	2	15	28.6	-1.7	1.171	0.4	0.3	0	38.7	30.1	0	125	103	0	35	33	34
2025	10	17	14	12	15	28.4	-2.7	1.172	0.4	0.3	0	38.7	30.1	0	125	103	0	35	33	35
2025	10	17	14	22	15	28.4	-2.3	1.172	0.5	0.4	0	39.1	30.1	0	125	103	0	34	33	34
2025	10	17	14	32	15	28.4	-3.4	1.172	0.3	0.2	0	37.8	29.2	0	123	102	0	35	34	35
2025	10	17	14	42	15	28.4	-3	1.171	0.3	0.2	0	38.3	30.1	0	124	103	0	35	33	35
2025	10	17	14	52	15	28.6	-2.8	1.171	0.4	0.3	0	39.1	29.7	0	125	103	0	34	34	34
2025	10	17	15	2	15	28.8	-2.3	1.172	0.4	0.3	0	39.1	29.7	0	125	103	0	34	34	34
2025	10	17	15	12	15	28.7	-2.9	1.171	0.4	0.3	0	38.7	29.7	0	125	103	0	35	34	34
2025	10	17	15	22	15	28.5	-3.2	1.172	0.3	0.2	0	38.7	30.1	0	124	103	0	34	33	34
2025	10	17	15	32	15	29	-2.9	1.171	0.3	0.2	0	38.7	30.1	0	124	103	0	34	33	35
2025	10	17	15	42	15	28.9	-3.4	1.171	0.3	0.2	0	38.7	29.2	0	124	102	0	34	34	34
2025	10	17	15	52	15	28.2	-2.4	1.171	0.4	0.3	0	38.7	30.5	0	125	104	0	35	33	36

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	17	16	2	15	27.7	-2.2	1.171	0.3	0.2	0	38.7	30.5	0	125	104	0	35	33	34
2025	10	17	16	12	15	28.8	-2.8	1.171	0.3	0.2	0	39.1	30.1	0	126	104	0	35	34	34
2025	10	17	16	22	15	28.1	-3.3	1.171	0.3	0.2	0	39.1	31	0	126	104	0	35	32	34
2025	10	17	16	32	15	29.2	-3.8	1.171	0.3	0.2	0	38.7	30.5	0	125	104	0	35	33	35
2025	10	17	16	42	15	28.7	-2.9	1.171	0.3	0.2	0	38.7	29.7	0	125	103	0	35	34	34
2025	10	17	16	52	15	27.3	-3.1	1.17	0.3	0.2	0	38.7	30.1	0	125	103	0	35	33	35
2025	10	17	17	2	15	28.3	-3.1	1.171	0.3	0.2	0	39.1	30.1	0	125	103	0	34	33	35
2025	10	17	17	12	15	28.5	-2.4	1.171	0.3	0.2	0	38.7	29.7	0	125	103	0	35	34	34
2025	10	17	17	22	15	28.3	-3.3	1.171	0.4	0.3	0	38.7	29.7	0	125	102	0	35	33	34
2025	10	17	17	32	15	28.1	-3.3	1.171	0.3	0.2	0	38.7	29.7	0	125	103	0	35	34	34
2025	10	17	17	42	15	29.1	-2.9	1.171	0.3	0.2	0	38.7	30.1	0	125	103	0	35	33	35
2025	10	17	17	52	15	28.3	-2.8	1.171	0.3	0.2	0	38.7	30.1	0	125	103	0	35	33	35
2025	10	17	18	2	15	29.1	-3.1	1.171	0.3	0.2	0	40	30.1	0	127	104	0	34	34	34
2025	10	17	18	12	15	29.4	-3.4	1.171	0.4	0.3	0	39.6	30.5	0	127	104	0	35	33	34
2025	10	17	18	22	15	27.6	-3.4	1.171	0.5	0.4	0	40	30.5	0	127	105	0	34	34	35
2025	10	17	18	32	15	29.5	-2	1.171	0.3	0.2	0	40	30.5	0	127	105	0	34	34	34
2025	10	17	18	42	15	28.9	-2.8	1.171	0.3	0.2	0	40	31.4	0	128	106	0	35	33	34
2025	10	17	18	52	15	28.3	-3.7	1.171	0.4	0.3	0	40.9	31.8	0	130	107	0	35	33	34
2025	10	17	19	2	15	28.8	-3.2	1.171	0.5	0.4	0	40.9	31.8	0	130	107	0	35	33	34
2025	10	17	19	12	15	28.2	-2.1	1.171	0.3	0.2	0	41.3	32.3	0	130	108	0	34	33	35
2025	10	17	19	22	15	29.2	-3.4	1.171	0.4	0.3	0	40.9	31.8	0	130	108	0	35	34	34
2025	10	17	19	32	15	28.8	-2.9	1.171	0.5	0.5	0	41.3	32.3	0	131	108	0	35	33	34
2025	10	17	19	42	15	28.9	-2.5	1.171	0.4	0.3	0	41.7	32.3	0	131	108	0	34	33	35
2025	10	17	19	52	15	29.9	-3.3	1.171	0.3	0.2	0	41.3	31.8	0	131	108	0	35	34	35
2025	10	17	20	2	15	29.9	-3.1	1.171	0.4	0.3	0	41.3	32.7	0	132	109	0	36	33	35
2025	10	17	20	12	15	29.7	-2.8	1.171	0.4	0.3	0	41.7	32.3	0	132	109	0	35	34	34
2025	10	17	20	22	15	28	-3.5	1.171	0.4	0.3	0	41.7	32.7	0	131	109	0	34	33	34
2025	10	17	20	32	15	29.3	-3	1.171	0.4	0.3	0	41.3	31.8	0	131	108	0	35	34	35
2025	10	17	20	42	15	29.5	-3	1.171	0.4	0.3	0	42.1	31.8	0	132	108	0	34	34	34
2025	10	17	20	52	15	28.8	-3.3	1.171	0.3	0.2	0	41.7	32.7	0	132	109	0	35	33	35
2025	10	17	21	2	15	27.3	-2.9	1.171	0.4	0.3	0	42.1	32.3	0	132	109	0	34	34	34
2025	10	17	21	12	15	28	-1.7	1.171	0.3	0.2	0	41.7	31.8	0	131	108	0	34	34	34
2025	10	17	21	22	15	28.3	-2.4	1.171	0.3	0.2	0	41.3	31.8	0	131	108	0	35	34	34
2025	10	17	21	32	15	29.8	-3.9	1.17	0.3	0.2	0	41.3	31.8	0	131	108	0	35	34	34
2025	10	17	21	42	15	29	-2.8	1.171	0.4	0.3	0	41.3	31.8	0	131	108	0	35	34	34
2025	10	17	21	52	15	28.5	-2.7	1.171	0.3	0.2	0	41.7	32.3	0	131	108	0	34	33	34
2025	10	17	22	2	15	28.5	-3.2	1.171	0.3	0.2	0	41.3	31.8	0	131	108	0	35	34	34
2025	10	17	22	12	15	28.2	-3	1.171	0.3	0.2	0	41.3	32.7	0	131	109	0	35	33	34
2025	10	17	22	22	15	29.3	-2.8	1.171	0.3	0.2	0	41.7	32.3	0	132	109	0	35	34	34
2025	10	17	22	32	15	29.5	-4.1	1.171	0.4	0.3	0	41.3	32.3	0	131	108	0	35	33	34
2025	10	17	22	42	15	28.6	-2.9	1.171	0.4	0.3	0	41.3	32.3	0	131	108	0	35	33	35
2025	10	17	22	52	15	28.7	-2.8	1.17	0.3	0.2	0	41.7	32.7	0	132	109	0	35	33	34
2025	10	17	23	2	15	29.4	-2.2	1.171	0.3	0.2	0	42.6	32.3	0	133	109	0	34	34	35
2025	10	17	23	12	15	29	-2.8	1.171	0.4	0.3	0	41.3	32.3	0	131	108	0	35	33	34
2025	10	17	23	22	15	29	-3.5	1.171	0.5	0.5	0	41.7	32.3	0	131	108	0	34	33	34
2025	10	17	23	32	15	29	-3.3	1.17	0.4	0.3	0	41.3	31.8	0	131	108	0	35	34	35
2025	10	17	23	42	15	29.4	-3.7	1.171	0.4	0.3	0	41.3	32.3	0	131	108	0	35	33	34
2025	10	17	23	52	15	30	-2.8	1.171	0.3	0.2	0	41.3	32.3	0	131	108	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	18	0	2	15	28.9	-3.1	1.17	0.4	0.3	0	40.9	31.4	0	130	108	0	35	35	35
2025	10	18	0	12	15	28.9	-3.3	1.171	0.3	0.2	0	40.9	31.4	0	130	107	0	35	34	35
2025	10	18	0	22	15	28.9	-3.3	1.17	0.4	0.3	0	41.3	31.4	0	130	107	0	34	34	34
2025	10	18	0	32	15	30.2	-3.5	1.17	0.3	0.2	0	41.3	31.8	0	130	107	0	34	33	35
2025	10	18	0	42	15	29.6	-3.7	1.17	0.3	0.2	0	41.3	31.8	0	130	107	0	34	33	35
2025	10	18	0	52	15	29.2	-3.6	1.17	0.4	0.3	0	40.9	31.4	0	130	107	0	35	34	35
2025	10	18	1	2	15	29	-3.3	1.17	0.5	0.4	0	40.9	31	0	130	106	0	35	34	35
2025	10	18	1	12	15	27.8	-2.5	1.17	0.4	0.3	0	40.9	31.4	0	130	107	0	35	34	34
2025	10	18	1	22	15	28.3	-3	1.17	0.3	0.2	0	40.9	31.8	0	130	107	0	35	33	35
2025	10	18	1	32	15	29.2	-2.9	1.17	0.4	0.3	0	41.3	31.4	0	130	107	0	34	34	34
2025	10	18	1	42	15	28.6	-2.8	1.17	0.3	0.2	0	41.3	31.4	0	130	107	0	34	34	35
2025	10	18	1	52	15	29.3	-2.7	1.17	0.4	0.3	0	40.9	31.4	0	130	107	0	35	34	35
2025	10	18	2	2	15	28.8	-2.7	1.17	0.3	0.2	0	40.9	31.4	0	130	107	0	35	34	34
2025	10	18	2	12	15	29.8	-2.5	1.17	0.4	0.3	0	41.3	31.4	0	130	107	0	34	34	34
2025	10	18	2	22	15	28.2	-3.1	1.17	0.3	0.2	0	40.9	31.4	0	130	107	0	35	34	34
2025	10	18	2	32	15	28.8	-2.7	1.17	0.3	0.2	0	40.9	31.8	0	130	107	0	35	33	35
2025	10	18	2	42	15	26.8	-3.1	1.17	0.3	0.2	0	40.9	32.3	0	130	108	0	35	33	35
2025	10	18	2	52	15	28.9	-2.8	1.17	0.3	0.2	0	40.9	31.4	0	130	107	0	35	34	35
2025	10	18	3	2	15	28	-1.9	1.17	0.4	0.3	0	41.3	31.4	0	131	107	0	35	34	35
2025	10	18	3	12	15	29.2	-2.9	1.17	0.5	0.4	0	41.3	31.8	0	130	107	0	34	33	35
2025	10	18	3	22	15	29.5	-2.3	1.17	0.3	0.2	0	40.9	31.4	0	130	106	0	35	33	34
2025	10	18	3	32	15	28.5	-3	1.17	0.4	0.3	0	40.9	31.4	0	130	107	0	35	34	34
2025	10	18	3	42	15	28.5	-3.5	1.17	0.5	0.4	0	40.9	31.4	0	130	107	0	35	34	35
2025	10	18	3	52	15	29.8	-3	1.17	0.3	0.2	0	40.9	31.4	0	130	106	0	35	33	34
2025	10	18	4	2	15	28.3	-3	1.169	0.4	0.3	0	40.9	31.8	0	130	107	0	35	33	34
2025	10	18	4	12	15	29.5	-2.9	1.17	0.4	0.3	0	40.9	31	0	129	106	0	34	34	35
2025	10	18	4	22	15	28.6	-2.7	1.17	0.3	0.2	0	40.4	31.4	0	129	106	0	35	33	34
2025	10	18	4	32	15	28.6	-2.3	1.17	0.3	0.2	0	40.4	31.4	0	129	106	0	35	33	35
2025	10	18	4	42	15	28.9	-2	1.17	0.3	0.2	0	40.4	31	0	129	106	0	35	34	35
2025	10	18	4	52	15	30.1	-3.2	1.17	0.5	0.4	0	40.9	31.4	0	130	106	0	35	33	34
2025	10	18	5	2	15	29.5	-3.6	1.169	0.4	0.3	0	40.9	31	0	129	106	0	34	34	34
2025	10	18	5	12	15	28.7	-3.3	1.169	0.3	0.2	0	40.4	31	0	129	106	0	35	34	34
2025	10	18	5	22	15	28.9	-2.3	1.169	0.3	0.2	0	40.9	31.8	0	130	107	0	35	33	34
2025	10	18	5	32	15	28.2	-2.8	1.17	0.3	0.2	0	40.9	31	0	129	106	0	34	34	35
2025	10	18	5	42	15	29.5	-3.6	1.17	0.3	0.2	0	40.9	31.4	0	130	106	0	35	33	34
2025	10	18	5	52	15	28.5	-3.1	1.17	0.3	0.2	0	40.9	30.5	0	129	105	0	34	34	35
2025	10	18	6	2	15	29.1	-2.7	1.169	0.3	0.2	0	40.9	31	0	130	106	0	35	34	34
2025	10	18	6	12	15	29.4	-3.2	1.169	0.4	0.3	0	40.9	30.5	0	129	105	0	34	34	34
2025	10	18	6	22	15	28.9	-3.9	1.169	0.3	0.2	0	40.4	30.5	0	129	105	0	35	34	34
2025	10	18	6	32	15	28.8	-2.8	1.169	0.5	0.4	0	40.4	30.5	0	129	105	0	35	34	35
2025	10	18	6	42	15	29.9	-2.2	1.169	0.3	0.2	0	40	30.5	0	128	105	0	35	34	35
2025	10	18	6	52	15	28.1	-4.3	1.169	0.3	0.2	0	40	30.1	0	128	104	0	35	34	35
2025	10	18	7	2	15	27.6	-2.3	1.169	0.3	0.2	0	40.4	30.1	0	128	104	0	34	34	34
2025	10	18	7	12	15	28.2	-2.8	1.169	0.3	0.2	0	39.6	30.1	0	127	103	0	35	33	35
2025	10	18	7	22	15	28.9	-3.4	1.169	0.3	0.2	0	40	29.7	0	127	103	0	34	34	34
2025	10	18	7	32	15	29.4	-3.5	1.169	0.3	0.2	0	39.1	29.7	0	126	103	0	35	34	34
2025	10	18	7	42	15	28.9	-3.3	1.169	0.4	0.3	0	39.1	29.2	0	126	102	0	35	34	35
2025	10	18	7	52	15	28.5	-2.5	1.169	0.3	0.2	0	39.1	29.7	0	126	102	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	18	8	2	15	29.3	-3.5	1.169	0.3	0.2	0	39.1	29.2	0	125	102	0	34	34	34
2025	10	18	8	12	15	29.3	-3.2	1.169	0.4	0.3	0	39.1	29.2	0	125	102	0	34	34	34
2025	10	18	8	22	15	29.1	-2.8	1.169	0.3	0.2	0	38.7	28.8	0	125	101	0	35	34	34
2025	10	18	8	32	15	28.2	-2.6	1.169	0.3	0.2	0	39.1	29.7	0	126	102	0	35	33	34
2025	10	18	8	42	15	28.9	-2.8	1.169	0.4	0.3	0	38.3	28.8	0	124	101	0	35	34	35
2025	10	18	8	52	15	28.5	-3.3	1.169	0.3	0.2	0	38.7	29.2	0	124	101	0	34	33	34
2025	10	18	9	2	15	29.5	-2.4	1.169	0.5	0.4	0	38.7	29.2	0	125	102	0	35	34	35
2025	10	18	9	12	15	27.9	-3.3	1.169	0.5	0.4	0	37.8	28.8	0	123	100	0	35	33	34
2025	10	18	9	22	15	28.6	-2.8	1.169	0.4	0.3	0	37.8	28.4	0	123	100	0	35	34	34
2025	10	18	9	32	15	28.5	-1.4	1.169	0.3	0.2	0	37.8	28.4	0	123	100	0	35	34	34
2025	10	18	9	42	15	28.3	-2.2	1.169	0.3	0.2	0	37.8	28.4	0	123	100	0	35	34	35
2025	10	18	9	52	15	28.8	-2.4	1.169	0.4	0.3	0	37.8	29.2	0	123	101	0	35	33	34
2025	10	18	10	2	15	28.9	-2.8	1.169	0.3	0.2	0	38.3	28.8	0	124	101	0	35	34	34
2025	10	18	10	12	15	28.3	-1.8	1.169	0.3	0.2	0	37.8	28.8	0	123	101	0	35	34	34
2025	10	18	10	22	15	27.6	-1.5	1.169	0.4	0.3	0	37.8	28.4	0	123	100	0	35	34	34
2025	10	18	10	32	15	28.1	-2.1	1.169	0.3	0.2	0	37.8	28.4	0	123	100	0	35	34	35
2025	10	18	10	42	15	27.5	-1.5	1.169	0.4	0.3	0	37.8	28.8	0	123	100	0	35	33	34
2025	10	18	10	52	15	28.4	-2.5	1.169	0.3	0.2	0	37.8	28.4	0	123	100	0	35	34	34
2025	10	18	11	2	15	28.4	-3.3	1.169	0.3	0.2	0	37.8	28.8	0	123	100	0	35	33	34
2025	10	18	11	12	15	28.1	-3.3	1.169	0.5	0.4	0	38.3	29.2	0	124	102	0	35	34	34
2025	10	18	11	22	15	28.7	-2.3	1.169	0.3	0.2	0	38.7	30.1	0	125	103	0	35	33	34
2025	10	18	11	32	15	29.7	-2	1.169	0.3	0.2	0	37.8	29.2	0	123	101	0	35	33	35
2025	10	18	11	42	15	29.1	-2.8	1.169	0.3	0.2	0	38.3	29.2	0	124	102	0	35	34	34
2025	10	18	11	52	15	29.2	-1.9	1.169	0.3	0.2	0	38.7	29.7	0	125	103	0	35	34	34
2025	10	18	12	2	15	28.7	-2.9	1.169	0.4	0.3	0	38.7	29.7	0	125	103	0	35	34	35
2025	10	18	12	12	15	28.7	-3.5	1.169	0.3	0.2	0	38.3	29.7	0	124	102	0	35	33	35
2025	10	18	12	22	15	27.7	-2.5	1.169	0.3	0.2	0	37.8	28.8	0	123	101	0	35	34	34
2025	10	18	12	32	15	28.6	-2.1	1.169	0.4	0.3	0	37.8	29.2	0	123	101	0	35	33	34
2025	10	18	12	42	15	28.1	-3.1	1.168	0.4	0.3	0	38.3	28.8	0	124	101	0	35	34	35
2025	10	18	12	52	15	27.3	-2.6	1.168	0.4	0.3	0	37.8	28.8	0	123	101	0	35	34	34
2025	10	18	13	2	15	27.9	-3	1.168	0.3	0.2	0	38.3	28.4	0	123	100	0	34	34	35
2025	10	18	13	12	15	27.5	-2.2	1.168	0.3	0.2	0	37.4	28	0	122	99	0	35	34	34
2025	10	18	13	22	15	28.4	-2.4	1.168	0.3	0.2	0	37.4	28.4	0	122	99	0	35	33	35
2025	10	18	13	32	15	27.3	-2.6	1.167	0.3	0.2	0	38.3	28.8	0	123	100	0	34	33	34
2025	10	18	13	42	15	28.4	-1.9	1.168	0.4	0.3	0	37.8	28.4	0	122	100	0	34	34	34
2025	10	18	13	52	15	27.8	-2.6	1.167	0.3	0.2	0	38.3	29.2	0	124	102	0	35	34	34
2025	10	18	14	2	15	27.5	-3.7	1.166	0.3	0.2	0	39.6	29.7	0	127	104	0	35	35	34
2025	10	18	14	12	15	29	-3	1.167	0.4	0.3	0	40.4	30.5	0	128	105	0	34	34	34
2025	10	18	14	22	15	28.2	-3.3	1.167	0.5	0.4	0	39.1	29.7	0	125	102	0	34	33	34
2025	10	18	14	32	15	28.8	-2.8	1.166	0.3	0.2	0	38.7	29.7	0	125	103	0	35	34	34
2025	10	18	14	42	15	28	-2.8	1.166	0.3	0.2	0	40	31	0	127	105	0	34	33	35
2025	10	18	14	52	15	27.8	-2.1	1.167	0.4	0.3	0	40.9	31.8	0	130	108	0	35	34	34
2025	10	18	15	2	15	29	-3.7	1.166	0.3	0.2	0	40	31	0	127	105	0	34	33	35
2025	10	18	15	12	15	28.5	-3.8	1.166	0.3	0.2	0	39.1	30.1	0	126	103	0	35	33	34
2025	10	18	15	22	15	27.8	-3.6	1.166	0.5	0.4	0	39.1	29.7	0	126	103	0	35	34	35
2025	10	18	15	32	15	27.9	-1.9	1.165	0.3	0.2	0	38.7	30.1	0	125	103	0	35	33	34
2025	10	18	15	42	15	29	-2.7	1.164	0.4	0.3	0	38.3	29.2	0	124	101	0	35	33	34
2025	10	18	15	52	15	28.1	-3.1	1.164	0.5	0.4	0	40	30.5	0	128	106	0	35	35	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	18	16	2	15	28.7	-2.9	1.164	0.3	0.2	0	39.6	30.5	0	127	104	0	35	33	34
2025	10	18	16	12	15	28.6	-2.3	1.164	0.3	0.2	0	39.1	29.7	0	126	103	0	35	34	34
2025	10	18	16	22	15	28.7	-2.9	1.164	0.5	0.4	0	39.1	30.1	0	126	103	0	35	33	34
2025	10	18	16	32	15	28.3	-3.3	1.163	0.5	0.4	0	39.1	29.2	0	125	102	0	34	34	34
2025	10	18	16	42	15	28.6	-2.3	1.163	0.4	0.3	0	38.7	29.2	0	124	101	0	34	33	34
2025	10	18	16	52	15	27.5	-2.7	1.163	0.3	0.2	0	38.7	29.2	0	124	101	0	34	33	34
2025	10	18	17	2	15	28.3	-3.1	1.162	0.4	0.3	0	38.3	28.8	0	124	101	0	35	34	34
2025	10	18	17	12	15	27.9	-2.9	1.162	0.3	0.2	0	39.6	30.5	0	127	104	0	35	33	34
2025	10	18	17	22	15	28.6	-2.9	1.161	0.3	0.2	0	39.1	30.1	0	126	103	0	35	33	34
2025	10	18	17	32	15	29.5	-3.3	1.161	0.3	0.2	0	38.7	29.2	0	125	101	0	35	33	34
2025	10	18	17	42	15	28.3	-3	1.161	0.5	0.4	0	38.7	29.7	0	125	102	0	35	33	34
2025	10	18	17	52	15	29.1	-4.2	1.161	0.4	0.3	0	38.7	29.7	0	125	102	0	35	33	34
2025	10	18	18	2	15	28.3	-2.7	1.161	0.3	0.2	0	39.1	29.2	0	126	102	0	35	34	34
2025	10	18	18	12	15	29.4	-2.6	1.161	0.4	0.3	0	39.6	30.1	0	127	103	0	35	33	35
2025	10	18	18	22	15	29.2	-3.6	1.16	0.4	0.3	0	39.6	30.5	0	127	104	0	35	33	34
2025	10	18	18	32	15	28.8	-3.5	1.16	0.5	0.4	0	39.6	29.7	0	127	104	0	35	35	35
2025	10	18	18	42	15	29	-2.7	1.16	0.3	0.2	0	40	30.1	0	128	104	0	35	34	35
2025	10	18	18	52	15	29.1	-3.3	1.16	0.3	0.2	0	40.4	31	0	128	105	0	34	33	34
2025	10	18	19	2	15	30.2	-3.4	1.16	0.4	0.3	0	40.4	30.5	0	129	105	0	35	34	35
2025	10	18	19	12	15	29.3	-3	1.16	0.3	0.2	0	40.9	30.5	0	129	105	0	34	34	35
2025	10	18	19	22	15	29.1	-2.5	1.16	0.3	0.2	0	40.9	31	0	130	106	0	35	34	34
2025	10	18	19	32	15	29.2	-3.6	1.16	0.4	0.3	0	40.9	31	0	130	106	0	35	34	34
2025	10	18	19	42	15	27.9	-2.1	1.159	0.3	0.2	0	40.9	31.4	0	130	106	0	35	33	34
2025	10	18	19	52	15	28.8	-3.2	1.159	0.3	0.2	0	40.9	31.8	0	130	107	0	35	33	34
2025	10	18	20	2	15	27.4	-3	1.159	0.3	0.2	0	40.9	31.8	0	130	107	0	35	33	35
2025	10	18	20	12	15	28.1	-2.6	1.159	0.3	0.2	0	40.9	31.4	0	130	107	0	35	34	35
2025	10	18	20	22	15	28.4	-2.8	1.159	0.4	0.3	0	40.9	31.4	0	130	107	0	35	34	34
2025	10	18	20	32	15	27.8	-2.6	1.159	0.3	0.2	0	41.3	31.8	0	131	107	0	35	33	34
2025	10	18	20	42	15	28.6	-3.8	1.159	0.3	0.2	0	41.7	31.8	0	131	107	0	34	33	35
2025	10	18	20	52	15	28.3	-2.4	1.159	0.3	0.2	0	41.3	31.4	0	131	107	0	35	34	34
2025	10	18	21	2	15	29.1	-3	1.159	0.3	0.2	0	41.3	31.8	0	131	107	0	35	33	34
2025	10	18	21	12	15	28.6	-3.3	1.159	0.4	0.3	0	41.7	31.4	0	131	107	0	34	34	34
2025	10	18	21	22	15	28.6	-3.2	1.158	0.3	0.2	0	41.7	31.4	0	131	107	0	34	34	34
2025	10	18	21	32	15	28	-3.2	1.158	0.3	0.2	0	41.3	31.8	0	131	107	0	35	33	34
2025	10	18	21	42	15	27.8	-3.8	1.158	0.3	0.2	0	40.9	31.4	0	130	107	0	35	34	34
2025	10	18	21	52	15	29.6	-3.5	1.158	0.3	0.2	0	41.3	31.8	0	130	107	0	34	33	35
2025	10	18	22	2	15	29	-3.2	1.158	0.4	0.3	0	40.9	31	0	130	106	0	35	34	35
2025	10	18	22	12	15	28.5	-3.2	1.158	0.4	0.3	0	40.9	31	0	129	106	0	34	34	35
2025	10	18	22	22	15	29.1	-3.2	1.158	0.3	0.2	0	40.9	31.4	0	130	106	0	35	33	35
2025	10	18	22	32	15	28.1	-2.5	1.158	0.3	0.2	0	41.3	31.8	0	131	107	0	35	33	34
2025	10	18	22	42	15	28.1	-3.7	1.157	0.3	0.2	0	40.9	31.4	0	130	106	0	35	33	34
2025	10	18	22	52	15	28.9	-2.5	1.157	0.3	0.2	0	40.4	30.5	0	129	105	0	35	34	34
2025	10	18	23	2	15	29.3	-3.7	1.157	0.3	0.2	0	40.9	31	0	129	106	0	34	34	34
2025	10	18	23	12	15	28.8	-4.9	1.157	0.4	0.3	0	40.4	30.5	0	129	105	0	35	34	34
2025	10	18	23	22	15	28.6	-3.7	1.157	0.4	0.3	0	40.9	31	0	129	106	0	34	34	35
2025	10	18	23	32	15	28.8	-4	1.157	0.4	0.3	0	40.4	30.5	0	129	105	0	35	34	35
2025	10	18	23	42	15	29.7	-3.7	1.157	0.4	0.3	0	40.4	31.4	0	129	106	0	35	33	34
2025	10	18	23	52	15	28.1	-2.9	1.157	0.3	0.2	0	40.4	31	0	129	105	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	19	0	2	15	29.3	-3.2	1.157	0.5	0.4	0	40.9	31	0	129	105	0	34	33	34
2025	10	19	0	12	15	28.5	-3.2	1.157	0.4	0.3	0	40.4	30.5	0	129	105	0	35	34	35
2025	10	19	0	22	15	28.4	-2.8	1.156	0.3	0.2	0	40.4	30.5	0	129	105	0	35	34	35
2025	10	19	0	32	15	27.6	-2.5	1.157	0.5	0.4	0	40.9	31	0	130	106	0	35	34	34
2025	10	19	0	42	15	28.5	-3	1.157	0.3	0.2	0	40.9	31	0	130	106	0	35	34	34
2025	10	19	0	52	15	30.2	-3.7	1.156	0.3	0.2	0	40.4	30.5	0	129	105	0	35	34	35
2025	10	19	1	2	15	28.6	-2.3	1.157	0.3	0.2	0	40.4	30.5	0	129	105	0	35	34	35
2025	10	19	1	12	15	29.3	-3.7	1.157	0.5	0.4	0	40.4	30.5	0	129	105	0	35	34	34
2025	10	19	1	22	15	29.4	-3.3	1.156	0.5	0.4	0	40.4	30.1	0	128	104	0	34	34	35
2025	10	19	1	32	15	27.9	-3.6	1.156	0.5	0.4	0	40.4	31	0	129	105	0	35	33	34
2025	10	19	1	42	15	28.2	-2.3	1.156	0.3	0.2	0	40.4	30.5	0	129	105	0	35	34	35
2025	10	19	1	52	15	28.1	-2.8	1.156	0.3	0.2	0	40.4	30.5	0	129	105	0	35	34	34
2025	10	19	2	2	15	29.6	-3.7	1.156	0.3	0.2	0	40	30.5	0	128	105	0	35	34	34
2025	10	19	2	12	15	29.8	-3.3	1.156	0.4	0.3	0	40.4	30.1	0	128	104	0	34	34	34
2025	10	19	2	22	15	27.3	-2.7	1.156	0.3	0.2	0	40.4	30.5	0	129	105	0	35	34	35
2025	10	19	2	32	15	27.7	-2.4	1.156	0.3	0.2	0	40.9	30.1	0	128	104	0	33	34	34
2025	10	19	2	42	15	28.6	-3.7	1.156	0.5	0.5	0	40.4	31	0	129	105	0	35	33	34
2025	10	19	2	52	15	28.8	-4.1	1.156	0.4	0.3	0	40	30.5	0	128	104	0	35	33	34
2025	10	19	3	2	15	28	-2.7	1.156	0.4	0.3	0	40.4	30.5	0	129	105	0	35	34	35
2025	10	19	3	12	15	29.1	-3.3	1.156	0.3	0.2	0	40.4	30.5	0	129	105	0	35	34	33
2025	10	19	3	22	15	29.4	-3.4	1.156	0.3	0.2	0	40	30.1	0	128	104	0	35	34	34
2025	10	19	3	32	15	28.2	-2.5	1.156	0.5	0.4	0	40	30.5	0	128	104	0	35	33	35
2025	10	19	3	42	15	29.3	-2.5	1.156	0.3	0.2	0	40.4	30.1	0	129	104	0	35	34	34
2025	10	19	3	52	15	29.3	-2.5	1.156	0.3	0.2	0	40.4	30.5	0	129	104	0	35	33	34
2025	10	19	4	2	15	29.5	-3.4	1.156	0.4	0.3	0	40.4	31	0	129	105	0	35	33	34
2025	10	19	4	12	15	28.6	-3.2	1.156	0.3	0.2	0	40.4	30.5	0	129	104	0	35	33	34
2025	10	19	4	22	15	28.5	-3.3	1.156	0.3	0.2	0	40.9	30.5	0	129	104	0	34	33	34
2025	10	19	4	32	15	28.6	-3.9	1.156	0.3	0.2	0	40.9	30.5	0	129	104	0	34	33	35
2025	10	19	4	42	15	27.5	-2.7	1.156	0.4	0.3	0	40.4	30.5	0	129	105	0	35	34	34
2025	10	19	4	52	15	28.9	-2.8	1.156	0.3	0.2	0	40.4	30.1	0	129	104	0	35	34	34
2025	10	19	5	2	15	28.4	-2.5	1.156	0.3	0.2	0	40	30.1	0	128	104	0	35	34	35
2025	10	19	5	12	15	29.2	-3.3	1.156	0.3	0.2	0	40.4	30.5	0	129	104	0	35	33	34
2025	10	19	5	22	15	29.3	-2.7	1.156	0.3	0.2	0	40.4	30.5	0	129	104	0	35	33	34
2025	10	19	5	32	15	29.1	-2.5	1.155	0.3	0.2	0	40.4	30.1	0	129	104	0	35	34	34
2025	10	19	5	42	15	28.2	-3.6	1.155	0.3	0.2	0	40	30.5	0	128	104	0	35	33	34
2025	10	19	5	52	15	29	-3	1.155	0.3	0.2	0	40.9	30.1	0	129	104	0	34	34	34
2025	10	19	6	2	15	28.3	-2.7	1.155	0.3	0.2	0	40.4	30.5	0	129	104	0	35	33	35
2025	10	19	6	12	15	28.5	-3.8	1.155	0.3	0.2	0	40.4	31	0	129	105	0	35	33	34
2025	10	19	6	22	15	28.8	-3.8	1.155	0.3	0.2	0	40.4	30.5	0	129	104	0	35	33	34
2025	10	19	6	32	15	28.6	-3.5	1.155	0.4	0.3	0	40.9	31	0	129	105	0	34	33	34
2025	10	19	6	42	15	27.8	-3.8	1.155	0.3	0.2	0	40	30.1	0	127	103	0	34	33	35
2025	10	19	6	52	15	28.2	-3.2	1.155	0.3	0.2	0	40	29.7	0	127	103	0	34	34	34
2025	10	19	7	2	15	27.8	-2.7	1.155	0.3	0.2	0	40	29.7	0	127	103	0	34	34	35
2025	10	19	7	12	15	29.2	-2.1	1.155	0.3	0.2	0	40	30.1	0	128	103	0	35	33	35
2025	10	19	7	22	15	27.3	-2.8	1.155	0.4	0.3	0	39.6	29.7	0	127	102	0	35	33	34
2025	10	19	7	32	15	27.9	-2.6	1.155	0.4	0.3	0	39.1	29.7	0	126	102	0	35	33	34
2025	10	19	7	42	15	28.7	-3.4	1.155	0.3	0.2	0	39.1	28.8	0	125	100	0	34	33	34
2025	10	19	7	52	15	28.9	-2.9	1.155	0.3	0.2	0	38.7	28.4	0	125	100	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	19	8	2	15	29	-3.3	1.155	0.4	0.3	0	39.6	29.2	0	126	101	0	34	33	34
2025	10	19	8	12	15	27.8	-2.8	1.155	0.4	0.3	0	38.7	28.8	0	125	101	0	35	34	34
2025	10	19	8	22	15	27.7	-2.9	1.155	0.3	0.2	0	38.7	29.2	0	125	101	0	35	33	34
2025	10	19	8	32	15	28.3	-2.7	1.155	0.4	0.3	0	38.7	28.8	0	125	101	0	35	34	34
2025	10	19	8	42	15	27.4	-2.6	1.155	0.3	0.2	0	39.1	28.8	0	125	101	0	34	34	34
2025	10	19	8	52	15	28.2	-3	1.155	0.3	0.2	0	38.7	28.8	0	125	100	0	35	33	34
2025	10	19	9	2	15	28.9	-3.3	1.155	0.3	0.2	0	38.7	28.4	0	124	100	0	34	34	34
2025	10	19	9	12	15	28.2	-2.9	1.155	0.5	0.4	0	38.7	28.4	0	124	100	0	34	34	34
2025	10	19	9	22	15	28.6	-3	1.155	0.3	0.2	0	38.3	28.8	0	124	100	0	35	33	34
2025	10	19	9	32	15	28.3	-2.3	1.155	0.4	0.3	0	38.3	28.8	0	124	100	0	35	33	34
2025	10	19	9	42	15	29.1	-3.8	1.155	0.4	0.3	0	38.3	28.4	0	124	100	0	35	34	34
2025	10	19	9	52	15	28.7	-2.9	1.155	0.3	0.2	0	38.7	28.8	0	125	100	0	35	33	35
2025	10	19	10	2	15	28.6	-1.7	1.155	0.3	0.2	0	38.7	28.8	0	125	101	0	35	34	35
2025	10	19	10	12	15	27.6	-3.4	1.155	0.4	0.3	0	38.3	28.4	0	124	100	0	35	34	34
2025	10	19	10	22	15	28.3	-2.5	1.155	0.3	0.2	0	38.3	28.4	0	124	100	0	35	34	35
2025	10	19	10	32	15	27.3	-3.9	1.155	0.3	0.2	0	38.7	29.2	0	124	100	0	34	32	34
2025	10	19	10	42	15	28.8	-2.5	1.155	0.3	0.2	0	37.8	28	0	123	99	0	35	34	34
2025	10	19	10	52	15	29.1	-3.1	1.155	0.4	0.3	0	37.8	27.5	0	122	98	0	34	34	34
2025	10	19	11	2	15	28.6	-4.2	1.155	0.3	0.2	0	37.8	28	0	123	99	0	35	34	34
2025	10	19	11	12	15	29	-3.8	1.155	0.4	0.3	0	37.4	28	0	122	99	0	35	34	34
2025	10	19	11	22	15	28.6	-2.8	1.155	0.3	0.2	0	37.8	28	0	123	99	0	35	34	34
2025	10	19	11	32	15	27.1	-1.9	1.155	0.3	0.2	0	37.8	27.5	0	122	98	0	34	34	34
2025	10	19	11	42	15	27.5	-2.3	1.155	0.4	0.3	0	37.8	27.5	0	122	98	0	34	34	34
2025	10	19	11	52	15	28.8	-2.8	1.154	0.6	0.5	0	38.7	28	0	124	99	0	34	34	34
2025	10	19	12	2	15	28.4	-3.5	1.154	0.3	0.2	0	38.7	28.4	0	124	100	0	34	34	35
2025	10	19	12	12	15	26.6	-2.2	1.152	0.4	0.3	0	38.3	28.4	0	123	100	0	34	34	34
2025	10	19	12	22	15	27.7	-1.7	1.153	0.3	0.2	0	37.8	28.4	0	123	99	0	35	33	34
2025	10	19	12	32	15	27.8	-1.7	1.153	0.4	0.3	0	38.3	28.4	0	124	100	0	35	34	34
2025	10	19	12	42	15	27.7	-2.5	1.153	0.4	0.3	0	38.3	28.4	0	123	100	0	34	34	35
2025	10	19	12	52	15	28.5	-1.9	1.152	0.3	0.2	0	38.7	28.4	0	124	100	0	34	34	34
2025	10	19	13	2	15	27.6	-3.2	1.152	0.3	0.2	0	38.3	28.4	0	124	100	0	35	34	34
2025	10	19	13	12	15	27.2	-2.1	1.152	0.4	0.3	0	38.7	28.8	0	124	101	0	34	34	34
2025	10	19	13	22	15	28.2	-2.7	1.152	0.4	0.3	0	38.7	29.2	0	125	101	0	35	33	34
2025	10	19	13	32	15	26.5	-1.7	1.152	0.5	0.4	0	38.7	29.7	0	125	101	0	35	32	34
2025	10	19	13	42	15	27.3	-2	1.151	0.5	0.4	0	38.7	29.7	0	125	102	0	35	33	34
2025	10	19	13	52	15	27.7	-2.8	1.152	0.3	0.2	0	40.9	31	0	129	105	0	34	33	34
2025	10	19	14	2	15	28.9	-2.1	1.151	0.3	0.2	0	40	30.5	0	128	105	0	35	34	35
2025	10	19	14	12	15	27.8	-1.7	1.151	0.3	0.2	0	39.1	29.2	0	126	102	0	35	34	34
2025	10	19	14	22	15	26.8	-2.6	1.15	0.5	0.4	0	38.7	29.2	0	125	102	0	35	34	34
2025	10	19	14	32	15	28.1	-2.5	1.15	0.3	0.2	0	38.7	28.8	0	125	101	0	35	34	34
2025	10	19	14	42	15	28.9	-3.1	1.15	0.3	0.2	0	38.3	29.2	0	124	101	0	35	33	34
2025	10	19	14	52	15	26.6	-3	1.15	0.4	0.3	0	39.1	30.1	0	126	103	0	35	33	35
2025	10	19	15	2	15	28.1	-2.5	1.15	0.4	0.3	0	40	31	0	128	105	0	35	33	35
2025	10	19	15	12	15	27.6	-1.9	1.15	0.5	0.4	0	39.6	30.1	0	127	104	0	35	34	34
2025	10	19	15	22	15	27.7	-2.9	1.149	0.3	0.2	0	38.7	29.2	0	125	101	0	35	33	34
2025	10	19	15	32	15	27.6	-3.1	1.149	0.3	0.2	0	38.7	29.2	0	125	101	0	35	33	35
2025	10	19	15	42	15	27.5	-2.3	1.149	0.3	0.2	0	38.7	29.2	0	125	101	0	35	33	34
2025	10	19	15	52	15	27.7	-2.4	1.149	0.4	0.3	0	39.1	29.2	0	125	101	0	34	33	34

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	10	19	16	2	15	28.4	-3.3	1.149	0.5	0.4	0	38.7	29.2	0	125	102	0	35	34	36	
2025	10	19	16	12	15	28.1	-2.6	1.149	0.4	0.3	0	39.1	29.7	0	125	102	0	34	33	34	
2025	10	19	16	22	15	28.8	-3.7	1.149	0.3	0.2	0	39.1	29.2	0	125	101	0	34	33	34	
2025	10	19	16	32	15	27	-2.3	1.149	0.3	0.2	0	38.3	28.8	0	124	100	0	35	33	34	
2025	10	19	16	42	15	28.2	-3.2	1.149	0.3	0.2	0	38.3	28.4	0	124	99	0	35	33	34	
2025	10	19	16	52	15	27.7	-3.2	1.149	0.3	0.2	0	38.7	28.4	0	124	100	0	34	34	35	
2025	10	19	17	2	15	28.4	-2.9	1.148	0.5	0.4	0	38.7	29.2	0	125	101	0	35	33	35	
2025	10	19	17	12	15	28	-3.7	1.148	0.5	0.4	0	38.7	28.8	0	125	101	0	35	34	35	
2025	10	19	17	22	15	27.8	-3.4	1.149	0.5	0.5	0	39.6	29.2	0	126	101	0	34	33	35	
2025	10	19	17	32	15	28	-3.6	1.148	0.4	0.3	0	39.1	29.2	0	126	102	0	35	34	35	
2025	10	19	17	42	15	28.2	-3.2	1.148	0.3	0.2	0	40	30.1	0	128	103	0	35	33	35	
2025	10	19	17	52	15	29.4	-3.4	1.148	0.4	0.3	0	39.6	29.7	0	127	102	0	35	33	34	
2025	10	19	18	2	15	28	-3.6	1.148	0.3	0.2	0	39.6	29.2	0	127	102	0	35	34	34	
2025	10	19	18	12	15	27.8	-2.5	1.148	0.3	0.2	0	40	29.7	0	127	103	0	34	34	34	
2025	10	19	18	22	15	28.6	-3.3	1.148	0.3	0.2	0	40	29.2	0	127	102	0	34	34	35	
2025	10	19	18	32	15	28.2	-1.9	1.148	0.4	0.3	0	40.4	30.1	0	128	104	0	34	34	34	
2025	10	19	18	42	15	28.1	-2.1	1.148	0.3	0.2	0	40	30.5	0	128	104	0	35	33	34	
2025	10	19	18	52	15	27.3	-2	1.148	0.3	0.2	0	40.4	30.5	0	129	105	0	35	34	35	
2025	10	19	19	2	15	28.2	-4	1.148	0.5	0.4	0	40.9	31	0	129	105	0	34	33	34	
2025	10	19	19	12	15	28.7	-2	1.148	0.4	0.3	0	41.7	31	0	131	105	0	34	33	35	
2025	10	19	19	22	15	27.8	-3.1	1.148	0.3	0.2	0	41.3	31	0	131	106	0	35	34	34	
2025	10	19	19	32	15	28.3	-3.9	1.148	0.5	0.4	0	40.9	31.4	0	130	106	0	35	33	34	
2025	10	19	19	42	15	27.9	-2.1	1.148	0.5	0.4	0	41.3	31.4	0	131	106	0	35	33	35	
2025	10	19	19	52	15	30	-4	1.148	0.3	0.2	0	41.7	31.8	0	132	107	0	35	33	34	
2025	10	19	20	2	15	28.1	-3.1	1.148	0.3	0.2	0	41.7	31.4	0	131	106	0	34	33	34	
2025	10	19	20	12	15	27.9	-2.8	1.148	0.4	0.3	0	41.7	31	0	131	106	0	34	34	34	
2025	10	19	20	22	15	29.3	-3.5	1.148	0.5	0.4	0	41.7	31.4	0	131	106	0	34	33	34	
2025	10	19	20	32	15	29.1	-3.8	1.148	0.3	0.2	0	41.3	31	0	131	106	0	35	34	34	
2025	10	19	20	42	15	29.1	-2.3	1.148	0.3	0.2	0	41.3	31.4	0	131	106	0	35	33	34	
2025	10	19	20	52	15	29.6	-2.8	1.148	0.4	0.3	0	41.3	31.4	0	131	106	0	35	33	35	
2025	10	19	21	2	15	28.6	-3.1	1.148	0.4	0.3	0	41.7	31	0	131	106	0	34	34	34	
2025	10	19	21	12	15	28.8	-2.4	1.148	0.4	0.3	0	41.3	31.4	0	131	106	0	35	33	34	
2025	10	19	21	22	15	28.6	-4.9	1.147	0.3	0.2	0	41.3	31.4	0	131	106	0	35	33	34	
2025	10	19	21	32	15	28.3	-3.3	1.147	0.5	0.4	0	41.3	31	0	130	106	0	34	34	35	
2025	10	19	21	42	15	28.1	-1.5	1.147	0.3	0.2	0	41.7	31	0	131	106	0	34	34	34	
2025	10	19	21	52	15	28.2	-3.4	1.147	0.4	0.3	0	41.3	31.4	0	131	106	0	35	33	34	
2025	10	19	22	2	15	28.7	-2.5	1.147	0.3	0.2	0	41.7	31.4	0	131	106	0	34	33	34	
2025	10	19	22	12	15	29.2	-2.3	1.147	0.3	0.2	0	41.3	31	0	131	106	0	35	34	35	
2025	10	19	22	22	15	28.8	-2.8	1.147	0.4	0.3	0	41.3	31.4	0	131	106	0	35	33	34	
2025	10	19	22	32	15	27.3	-2.8	1.148	0.3	0.2	0	41.7	31.8	0	132	107	0	35	33	34	
2025	10	19	22	42	15	28.5	-2.5	1.147	0.4	0.3	0	41.7	31	0	131	106	0	34	34	35	
2025	10	19	22	52	15	28.8	-3.5	1.147	0.5	0.4	0	41.3	31	0	131	106	0	35	34	34	
2025	10	19	23	2	15	28.2	-3.6	1.147	0.3	0.2	0	41.3	31	0	130	106	0	34	34	34	
2025	10	19	23	12	15	27.4	-2.9	1.147	0.4	0.3	0	41.3	31.4	0	131	107	0	35	34	35	
2025	10	19	23	22	15	28.8	-2.8	1.147	0.3	0.2	0	41.7	31.4	0	131	107	0	34	34	34	
2025	10	19	23	32	15	28	-3.2	1.147	0.3	0.2	0	41.3	31.8	0	131	107	0	35	33	34	
2025	10	19	23	42	15	29	-3.3	1.147	0.4	0.3	0	41.3	31.4	0	131	106	0	35	33	34	
2025	10	19	23	52	15	27.3	-1.8	1.147	0.5	0.4	0	41.3	31	0	131	106	0	35	34	35	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	20	0	2	15	28.8	-2.8	1.147	0.5	0.4	0	41.7	31	0	131	106	0	34	34	34
2025	10	20	0	12	15	26.9	-2.5	1.147	0.4	0.3	0	41.7	31.4	0	131	106	0	34	33	34
2025	10	20	0	22	15	28.1	-2.5	1.147	0.4	0.3	0	41.3	31.4	0	131	106	0	35	33	34
2025	10	20	0	32	15	29.1	-3	1.147	0.5	0.4	0	41.3	31	0	131	106	0	35	34	35
2025	10	20	0	42	15	29.4	-2.9	1.147	0.3	0.2	0	40.9	30.5	0	130	105	0	35	34	34
2025	10	20	0	52	15	27.7	-2.7	1.147	0.5	0.4	0	41.7	31.4	0	131	107	0	34	34	34
2025	10	20	1	2	15	27	-2.5	1.147	0.5	0.4	0	43	32.7	0	134	110	0	34	34	34
2025	10	20	1	12	15	28.7	-2.7	1.147	0.4	0.3	0	41.7	31.8	0	132	107	0	35	33	34
2025	10	20	1	22	15	27.9	-2.9	1.147	0.3	0.2	0	41.3	31	0	131	106	0	35	34	35
2025	10	20	1	32	15	29.4	-3.1	1.147	0.3	0.2	0	41.7	31.4	0	131	106	0	34	33	34
2025	10	20	1	42	15	27.2	-2.4	1.147	0.3	0.2	0	41.3	31.4	0	131	106	0	35	33	34
2025	10	20	1	52	15	28.5	-3.2	1.147	0.4	0.3	0	41.3	30.5	0	130	105	0	34	34	34
2025	10	20	2	2	15	27.9	-2.9	1.147	0.4	0.3	0	41.7	31.4	0	131	106	0	34	33	34
2025	10	20	2	12	15	28.4	-2.6	1.147	0.4	0.3	0	40.9	30.5	0	130	105	0	35	34	35
2025	10	20	2	22	15	28.2	-3.7	1.147	0.3	0.2	0	41.3	30.5	0	130	105	0	34	34	35
2025	10	20	2	32	15	27.9	-2.6	1.147	0.3	0.2	0	41.3	31.4	0	131	106	0	35	33	35
2025	10	20	2	42	15	27.7	-2.2	1.147	0.3	0.2	0	41.3	31	0	131	106	0	35	34	34
2025	10	20	2	52	15	28.6	-2.5	1.147	0.4	0.3	0	41.3	30.5	0	130	105	0	34	34	34
2025	10	20	3	2	15	28.4	-2.8	1.147	0.4	0.3	0	40.9	30.5	0	130	105	0	35	34	34
2025	10	20	3	12	15	28.6	-3.7	1.147	0.4	0.3	0	41.3	31	0	130	105	0	34	33	34
2025	10	20	3	22	15	27.9	-3.1	1.147	0.3	0.2	0	41.3	30.5	0	130	105	0	34	34	35
2025	10	20	3	32	15	27.4	-2.9	1.147	0.3	0.2	0	40.9	30.5	0	130	105	0	35	34	35
2025	10	20	3	42	15	29.1	-2.8	1.147	0.4	0.3	0	40.9	30.5	0	130	105	0	35	34	35
2025	10	20	3	52	15	28.2	-2.2	1.147	0.4	0.3	0	41.3	31	0	130	105	0	34	33	34
2025	10	20	4	2	15	28.6	-3.3	1.147	0.3	0.2	0	40.9	30.5	0	130	105	0	35	34	35
2025	10	20	4	12	15	28.2	-2.5	1.147	0.4	0.3	0	41.3	31	0	130	106	0	34	34	34
2025	10	20	4	22	15	27.8	-2.8	1.147	0.4	0.3	0	40.9	31.4	0	130	105	0	35	32	34
2025	10	20	4	32	15	27.1	-2.3	1.147	0.3	0.2	0	41.7	31.4	0	131	106	0	34	33	34
2025	10	20	4	42	15	27.8	-2.8	1.147	0.4	0.3	0	40.9	31	0	130	106	0	35	34	34
2025	10	20	4	52	15	28.1	-2.6	1.147	0.4	0.3	0	40.9	30.5	0	130	105	0	35	34	34
2025	10	20	5	2	15	28.5	-3.3	1.147	0.3	0.2	0	41.3	31	0	130	105	0	34	33	34
2025	10	20	5	12	15	28.8	-2.9	1.147	0.4	0.3	0	40.9	31	0	130	105	0	35	33	35
2025	10	20	5	22	15	27.8	-2.6	1.147	0.3	0.2	0	40.9	31.4	0	130	106	0	35	33	34
2025	10	20	5	32	15	28.5	-2.2	1.147	0.4	0.3	0	41.3	30.5	0	130	105	0	34	34	34
2025	10	20	5	42	15	28.8	-2.4	1.147	0.5	0.5	0	40.9	31	0	130	105	0	35	33	35
2025	10	20	5	52	15	28.7	-2.9	1.147	0.4	0.3	0	41.3	30.5	0	130	105	0	34	34	35
2025	10	20	6	2	15	27.7	-2.5	1.147	0.3	0.2	0	40.9	30.5	0	129	105	0	34	34	34
2025	10	20	6	12	15	27.1	-3.5	1.147	0.4	0.3	0	40.4	31	0	129	105	0	35	33	34
2025	10	20	6	22	15	28.3	-2.1	1.147	0.4	0.3	0	40.9	30.5	0	129	105	0	34	34	34
2025	10	20	6	32	15	28.1	-2.8	1.147	0.5	0.5	0	41.3	31	0	130	105	0	34	33	34
2025	10	20	6	42	15	26.7	-2.5	1.147	0.3	0.2	0	40.9	30.5	0	130	105	0	35	34	35
2025	10	20	6	52	15	26.9	-3	1.147	0.3	0.2	0	40.4	30.5	0	129	105	0	35	34	35
2025	10	20	7	2	15	28.4	-1.8	1.147	0.3	0.2	0	40.4	30.1	0	129	104	0	35	34	35
2025	10	20	7	12	15	27.9	-3.5	1.147	0.3	0.2	0	40.4	30.1	0	128	104	0	34	34	34
2025	10	20	7	22	15	27.6	-3.3	1.146	0.3	0.2	0	40.4	29.7	0	128	103	0	34	34	35
2025	10	20	7	32	15	27.1	-2.5	1.147	0.3	0.2	0	39.6	29.7	0	127	102	0	35	33	34
2025	10	20	7	42	15	29.4	-3.6	1.147	0.4	0.3	0	39.6	29.7	0	126	102	0	34	33	34
2025	10	20	7	52	15	28.7	-2.6	1.146	0.4	0.3	0	39.1	29.2	0	126	102	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	20	8	2	15	27.5	-2.4	1.146	0.3	0.2	0	39.6	29.2	0	127	102	0	35	34	33
2025	10	20	8	12	15	29.1	-2.8	1.146	0.3	0.2	0	39.1	29.2	0	126	102	0	35	34	34
2025	10	20	8	22	15	28.6	-2.6	1.147	0.3	0.2	0	39.1	28.8	0	126	101	0	35	34	34
2025	10	20	8	32	15	27.5	-2.8	1.147	0.4	0.3	0	39.1	29.2	0	126	102	0	35	34	34
2025	10	20	8	42	15	29.6	-2.6	1.147	0.3	0.2	0	39.1	29.7	0	126	102	0	35	33	34
2025	10	20	8	52	15	27.9	-2.8	1.147	0.4	0.3	0	39.6	28.4	0	126	101	0	34	35	34
2025	10	20	9	2	15	27.5	-3.2	1.147	0.3	0.2	0	39.6	29.7	0	126	102	0	34	33	34
2025	10	20	9	12	15	27.9	-1.8	1.147	0.3	0.2	0	38.7	29.2	0	125	101	0	35	33	34
2025	10	20	9	22	15	28.8	-3	1.147	0.3	0.2	0	39.1	29.2	0	125	101	0	34	33	35
2025	10	20	9	32	15	27.5	-2.5	1.147	0.3	0.2	0	39.1	29.2	0	125	101	0	34	33	34
2025	10	20	9	42	15	29.5	-3.3	1.147	0.3	0.2	0	38.3	28.4	0	124	100	0	35	34	34
2025	10	20	9	52	15	28.2	-3	1.147	0.4	0.3	0	38.7	28.8	0	125	101	0	35	34	34
2025	10	20	10	2	15	26.9	-2.4	1.147	0.4	0.3	0	38.3	28.8	0	124	101	0	35	34	34
2025	10	20	10	12	15	27.8	-2.1	1.147	0.4	0.3	0	38.3	28.8	0	124	100	0	35	33	34
2025	10	20	10	22	15	28.5	-2.1	1.147	0.4	0.3	0	38.7	29.7	0	125	102	0	35	33	35
2025	10	20	10	32	15	28.9	-2.2	1.147	0.4	0.3	0	38.3	28.8	0	124	101	0	35	34	35
2025	10	20	10	42	15	28.1	-3	1.147	0.3	0.2	0	38.3	28.8	0	124	100	0	35	33	34
2025	10	20	10	52	15	27.7	-2.4	1.147	0.5	0.5	0	38.7	29.7	0	125	102	0	35	33	34
2025	10	20	11	2	15	28.1	-3.6	1.148	0.4	0.3	0	38.3	28.4	0	124	100	0	35	34	34
2025	10	20	11	12	15	27.5	-2.1	1.148	0.3	0.2	0	38.7	29.2	0	125	101	0	35	33	34
2025	10	20	11	22	15	27.2	-2.6	1.147	0.3	0.2	0	38.7	29.2	0	125	102	0	35	34	35
2025	10	20	11	32	15	28.6	-3.4	1.148	0.3	0.2	0	38.3	28.4	0	124	100	0	35	34	35
2025	10	20	11	42	15	27.9	-4.2	1.147	0.4	0.3	0	38.3	28.4	0	124	100	0	35	34	33
2025	10	20	11	52	15	27.7	-2.9	1.148	0.3	0.2	0	37.8	28.8	0	123	100	0	35	33	34
2025	10	20	12	2	15	28.9	-3.4	1.148	0.3	0.2	0	37.8	28	0	122	99	0	34	34	34
2025	10	20	12	12	15	28.2	-2.4	1.148	0.4	0.3	0	38.3	28.4	0	124	100	0	35	34	34
2025	10	20	12	22	15	28.7	-3.4	1.148	0.3	0.2	0	38.3	28.4	0	123	99	0	34	33	34
2025	10	20	12	32	15	28.5	-2.5	1.148	0.3	0.2	0	37.8	28.8	0	123	100	0	35	33	34
2025	10	20	12	42	15	28.6	-3.4	1.148	0.4	0.3	0	38.3	28.4	0	124	100	0	35	34	34
2025	10	20	12	52	15	28.5	-3	1.148	0.4	0.3	0	38.3	28.8	0	123	100	0	34	33	35
2025	10	20	13	2	15	28.4	-3.3	1.148	0.3	0.2	0	37.8	28.8	0	123	100	0	35	33	34
2025	10	20	13	12	15	28.3	-2.9	1.148	0.4	0.3	0	38.3	28.4	0	123	99	0	34	33	34
2025	10	20	13	22	15	28.2	-3.3	1.148	0.3	0.2	0	37.8	28.4	0	122	99	0	34	33	34
2025	10	20	13	32	15	28.3	-2.9	1.148	0.4	0.3	0	38.3	28.8	0	123	100	0	34	33	35
2025	10	20	13	42	15	27.1	-2.1	1.148	0.4	0.3	0	37.8	28.8	0	123	100	0	35	33	34
2025	10	20	13	52	15	27.3	-2.8	1.148	0.4	0.3	0	38.3	28.4	0	124	100	0	35	34	34
2025	10	20	14	2	15	27.8	-4.6	1.148	0.4	0.3	0	38.3	28.4	0	123	99	0	34	33	35
2025	10	20	14	12	15	28.2	-3.4	1.148	0.3	0.2	0	38.3	28	0	123	99	0	34	34	35
2025	10	20	14	22	15	29	-3.6	1.148	0.3	0.2	0	37.8	28	0	123	99	0	35	34	34
2025	10	20	14	32	15	28.6	-2.8	1.147	0.3	0.2	0	37.8	28.4	0	122	99	0	34	33	34
2025	10	20	14	42	15	27.7	-3.1	1.148	0.3	0.2	0	37.4	28	0	122	99	0	35	34	34
2025	10	20	14	52	15	29.2	-4.5	1.148	0.4	0.3	0	38.3	28.8	0	123	100	0	34	33	34
2025	10	20	15	2	15	28.6	-3.1	1.147	0.4	0.3	0	38.3	28.4	0	123	99	0	34	33	34
2025	10	20	15	12	15	28.3	-3.3	1.148	0.4	0.3	0	37.8	28.4	0	123	100	0	35	34	34
2025	10	20	15	22	15	28.2	-3.3	1.147	0.4	0.3	0	37.8	28.8	0	123	99	0	35	32	34
2025	10	20	15	32	15	28.4	-3	1.147	0.3	0.2	0	38.3	28.8	0	123	100	0	34	33	34
2025	10	20	15	42	15	27.5	-3.1	1.147	0.4	0.3	0	38.3	28	0	123	99	0	34	34	34
2025	10	20	15	52	15	27.7	-2.7	1.147	0.3	0.2	0	38.3	28.4	0	124	100	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	20	16	2	15	28	-4.4	1.147	0.3	0.2	0	38.3	28.4	0	124	100	0	35	34	34
2025	10	20	16	12	15	27.1	-2.7	1.147	0.5	0.4	0	38.3	28.8	0	124	100	0	35	33	34
2025	10	20	16	22	15	27.6	-3	1.147	0.3	0.2	0	38.7	29.2	0	125	101	0	35	33	34
2025	10	20	16	32	15	28.6	-4.2	1.147	0.3	0.2	0	38.3	28.4	0	124	100	0	35	34	34
2025	10	20	16	42	15	27.7	-3.4	1.147	0.5	0.5	0	38.7	29.2	0	125	101	0	35	33	35
2025	10	20	16	52	15	28.2	-3.2	1.147	0.4	0.3	0	38.7	28.4	0	124	100	0	34	34	34
2025	10	20	17	2	15	28.1	-4	1.147	0.5	0.5	0	39.1	28.8	0	125	101	0	34	34	35
2025	10	20	17	12	15	28.8	-3.3	1.146	0.3	0.2	0	38.3	28.4	0	124	100	0	35	34	34
2025	10	20	17	22	15	27.5	-2.5	1.146	0.5	0.4	0	38.7	28.8	0	124	100	0	34	33	34
2025	10	20	17	32	15	28.7	-4.1	1.146	0.3	0.2	0	37.8	28.4	0	123	99	0	35	33	34
2025	10	20	17	42	15	27.7	-3.3	1.146	0.3	0.2	0	39.1	29.2	0	125	101	0	34	33	35
2025	10	20	17	52	15	28	-2.9	1.146	0.4	0.3	0	39.6	28.8	0	126	101	0	34	34	35
2025	10	20	18	2	15	28.1	-2.6	1.146	0.4	0.3	0	38.7	29.2	0	125	101	0	35	33	35
2025	10	20	18	12	15	28.1	-2.2	1.146	0.4	0.3	0	39.1	28.8	0	125	101	0	34	34	34
2025	10	20	18	22	15	27.8	-2.1	1.146	0.4	0.3	0	40	29.7	0	127	102	0	34	33	34
2025	10	20	18	32	15	28.7	-4.1	1.146	0.4	0.3	0	40	29.7	0	127	102	0	34	33	33
2025	10	20	18	42	15	28.1	-2.8	1.146	0.4	0.3	0	40	30.5	0	128	104	0	35	33	34
2025	10	20	18	52	15	27.3	-2.6	1.146	0.4	0.3	0	40.4	30.1	0	129	104	0	35	34	34
2025	10	20	19	2	15	29.2	-3.7	1.146	0.4	0.3	0	40.4	30.1	0	129	104	0	35	34	34
2025	10	20	19	12	15	27.7	-2.7	1.146	0.3	0.2	0	41.3	31	0	130	105	0	34	33	34
2025	10	20	19	22	15	28.3	-3.4	1.146	0.3	0.2	0	40.4	30.5	0	129	105	0	35	34	34
2025	10	20	19	32	15	28	-3.3	1.146	0.3	0.2	0	41.3	31	0	130	106	0	34	34	35
2025	10	20	19	42	15	28.2	-2.2	1.146	0.3	0.2	0	41.3	30.5	0	130	105	0	34	34	34
2025	10	20	19	52	15	28.8	-3.7	1.146	0.3	0.2	0	40	29.7	0	127	103	0	34	34	34
2025	10	20	20	2	15	28.5	-3.7	1.146	0.3	0.2	0	40.9	31	0	130	106	0	35	34	34
2025	10	20	20	12	15	28.4	-3	1.146	0.5	0.4	0	41.3	31.4	0	130	106	0	34	33	34
2025	10	20	20	22	15	27.4	-3.3	1.146	0.4	0.3	0	41.3	31.8	0	131	107	0	35	33	34
2025	10	20	20	32	15	28.1	-2.3	1.146	0.4	0.3	0	41.3	31.4	0	130	106	0	34	33	35
2025	10	20	20	42	15	28	-2.4	1.146	0.4	0.3	0	41.7	31	0	131	106	0	34	34	35
2025	10	20	20	52	15	29.1	-2.6	1.146	0.4	0.3	0	40.9	31	0	130	106	0	35	34	34
2025	10	20	21	2	15	27.9	-2.7	1.146	0.4	0.3	0	41.7	31	0	131	106	0	34	34	34
2025	10	20	21	12	15	28.3	-3.3	1.145	0.5	0.4	0	41.3	31.4	0	131	106	0	35	33	34
2025	10	20	21	22	15	28.2	-2.5	1.145	0.3	0.2	0	41.7	31	0	131	106	0	34	34	34
2025	10	20	21	32	15	28.3	-3.3	1.146	0.3	0.2	0	40.9	31	0	130	106	0	35	34	35
2025	10	20	21	42	15	27.8	-2	1.146	0.4	0.3	0	42.1	32.3	0	133	108	0	35	33	34
2025	10	20	21	52	15	28.7	-2.4	1.145	0.4	0.3	0	41.7	31.8	0	131	107	0	34	33	34
2025	10	20	22	2	15	28.3	-2.5	1.145	0.5	0.4	0	41.7	31.8	0	131	107	0	34	33	34
2025	10	20	22	12	15	28.7	-3.4	1.145	0.3	0.2	0	40.9	31	0	130	106	0	35	34	35
2025	10	20	22	22	15	28.3	-3.3	1.145	0.4	0.3	0	41.3	31.4	0	131	107	0	35	34	34
2025	10	20	22	32	15	28.9	-2.8	1.145	0.3	0.2	0	41.7	31.4	0	131	107	0	34	34	35
2025	10	20	22	42	15	28.3	-2.7	1.145	0.3	0.2	0	41.3	31.4	0	131	106	0	35	33	34
2025	10	20	22	52	15	27.9	-3.3	1.145	0.4	0.3	0	41.7	31	0	131	106	0	34	34	35
2025	10	20	23	2	15	28.7	-3.8	1.145	0.3	0.2	0	41.3	31.4	0	131	106	0	35	33	34
2025	10	20	23	12	15	26.4	-2.5	1.145	0.4	0.3	0	41.3	30.1	0	131	104	0	35	34	34
2025	10	20	23	22	15	29.2	-3.3	1.145	0.3	0.2	0	40.9	31	0	130	106	0	35	34	34
2025	10	20	23	32	15	28.7	-2	1.145	0.4	0.3	0	40.9	31.4	0	130	106	0	35	33	34
2025	10	20	23	42	15	28.3	-3.5	1.145	0.5	0.5	0	41.7	31.4	0	131	106	0	34	33	34
2025	10	20	23	52	15	27.4	-2.1	1.145	0.3	0.2	0	41.3	31.4	0	131	107	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	21	0	2	15	28	-4.2	1.145	0.3	0.2	0	40.9	31	0	130	106	0	35	34	34
2025	10	21	0	12	15	28.3	-2.4	1.145	0.3	0.2	0	41.3	31	0	130	106	0	34	34	34
2025	10	21	0	22	15	28	-2.7	1.145	0.3	0.2	0	41.3	30.5	0	130	105	0	34	34	35
2025	10	21	0	32	15	28.8	-3.8	1.145	0.4	0.3	0	41.3	30.5	0	130	104	0	34	33	34
2025	10	21	0	42	15	27.9	-3.3	1.145	0.3	0.2	0	40.9	30.5	0	130	105	0	35	34	34
2025	10	21	0	52	15	26.7	-2.3	1.145	0.3	0.2	0	40.9	30.5	0	130	105	0	35	34	34
2025	10	21	1	2	15	27.8	-2.5	1.145	0.3	0.2	0	40.9	31	0	130	105	0	35	33	34
2025	10	21	1	12	15	28	-3.2	1.145	0.4	0.3	0	40.9	31	0	130	105	0	35	33	34
2025	10	21	1	22	15	27.8	-3.1	1.145	0.3	0.2	0	41.7	31	0	131	106	0	34	34	34
2025	10	21	1	32	15	28.4	-1.7	1.144	0.4	0.3	0	41.3	31	0	131	106	0	35	34	35
2025	10	21	1	42	15	28.3	-3	1.144	0.3	0.2	0	41.3	31	0	130	105	0	34	33	35
2025	10	21	1	52	15	27.1	-3.5	1.145	0.5	0.5	0	41.3	31.4	0	131	106	0	35	33	34
2025	10	21	2	2	15	27.9	-1.9	1.144	0.4	0.3	0	40.9	31.4	0	130	106	0	35	33	34
2025	10	21	2	12	15	27.7	-2.1	1.144	0.5	0.4	0	40.9	30.5	0	130	105	0	35	34	34
2025	10	21	2	22	15	28.4	-2.5	1.144	0.4	0.3	0	40.9	30.5	0	130	105	0	35	34	34
2025	10	21	2	32	15	28.1	-3.4	1.144	0.3	0.2	0	41.3	30.5	0	130	105	0	34	34	34
2025	10	21	2	42	15	27.3	-2.8	1.144	0.3	0.2	0	40.9	30.5	0	130	105	0	35	34	35
2025	10	21	2	52	15	28.3	-2.9	1.144	0.4	0.3	0	40.4	31	0	130	105	0	36	33	34
2025	10	21	3	2	15	28.6	-2.8	1.144	0.3	0.2	0	40.9	30.5	0	130	105	0	35	34	34
2025	10	21	3	12	15	28.2	-2.7	1.144	0.3	0.2	0	41.3	31	0	130	105	0	34	33	35
2025	10	21	3	22	15	27.3	-1.3	1.144	0.5	0.4	0	40.9	31	0	130	106	0	35	34	34
2025	10	21	3	32	15	27.4	-2.4	1.144	0.6	0.5	0	40.9	31.4	0	130	106	0	35	33	34
2025	10	21	3	42	15	28	-3	1.143	0.3	0.2	0	41.3	30.5	0	130	105	0	34	34	34
2025	10	21	3	52	15	28.4	-3.1	1.143	0.5	0.4	0	40.9	30.5	0	130	105	0	35	34	34
2025	10	21	4	2	15	27.6	-2.5	1.143	0.4	0.3	0	41.7	31	0	131	105	0	34	33	34
2025	10	21	4	12	15	28.4	-3.7	1.143	0.3	0.2	0	41.7	30.5	0	132	105	0	35	34	34
2025	10	21	4	22	15	27.8	-2.3	1.143	0.4	0.3	0	41.3	30.5	0	131	105	0	35	34	34
2025	10	21	4	32	15	26.8	-2.8	1.143	0.5	0.4	0	42.1	31.4	0	132	106	0	34	33	34
2025	10	21	4	42	15	27.1	-2.6	1.142	0.5	0.4	0	41.3	30.5	0	131	105	0	35	34	34
2025	10	21	4	52	15	27.6	-2.3	1.142	0.3	0.2	0	41.3	30.5	0	131	105	0	35	34	34
2025	10	21	5	2	15	29	-2.5	1.142	0.4	0.3	0	41.3	31	0	131	105	0	35	33	35
2025	10	21	5	12	15	26.7	-1.8	1.142	0.4	0.3	0	41.3	30.5	0	131	105	0	35	34	34
2025	10	21	5	22	15	26.8	-3.6	1.141	0.4	0.3	0	41.3	30.5	0	131	105	0	35	34	35
2025	10	21	5	32	15	27.9	-4	1.142	0.3	0.2	0	41.3	30.5	0	131	105	0	35	34	34
2025	10	21	5	42	15	27.4	-3.2	1.142	0.3	0.2	0	41.7	31	0	131	105	0	34	33	34
2025	10	21	5	52	15	28.2	-2.1	1.141	0.3	0.2	0	41.3	31	0	130	105	0	34	33	34
2025	10	21	6	2	15	27.7	-2.5	1.14	0.3	0.2	0	41.7	31	0	131	105	0	34	33	34
2025	10	21	6	12	15	27.5	-3.3	1.14	0.3	0.2	0	41.3	30.5	0	131	105	0	35	34	34
2025	10	21	6	22	15	28.1	-2.9	1.139	0.3	0.2	0	40.9	30.5	0	130	105	0	35	34	35
2025	10	21	6	32	15	27.4	-3.2	1.138	0.4	0.3	0	40.9	30.5	0	130	105	0	35	34	34
2025	10	21	6	42	15	28	-3.8	1.138	0.4	0.3	0	40.9	30.1	0	130	104	0	35	34	34
2025	10	21	6	52	15	28.1	-3.3	1.138	0.3	0.2	0	40.9	30.1	0	130	104	0	35	34	34
2025	10	21	7	2	15	27.5	-2.1	1.138	0.4	0.3	0	40.9	30.1	0	130	104	0	35	34	34
2025	10	21	7	12	15	28	-3.3	1.138	0.3	0.2	0	40.9	30.1	0	130	104	0	35	34	34
2025	10	21	7	22	15	28.7	-2.2	1.138	0.3	0.2	0	40.9	29.7	0	129	103	0	34	34	34
2025	10	21	7	32	15	27.8	-2.8	1.137	0.3	0.2	0	40.9	29.7	0	129	103	0	34	34	34
2025	10	21	7	42	15	29.4	-2.6	1.137	0.5	0.4	0	40	29.2	0	128	101	0	35	33	35
2025	10	21	7	52	15	27.4	-3	1.137	0.4	0.3	0	40	29.7	0	128	102	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	21	8	2	15	27.7	-2.7	1.137	0.3	0.2	0	39.6	29.7	0	127	102	0	35	33	35
2025	10	21	8	12	15	28.8	-3.5	1.137	0.4	0.3	0	39.6	29.2	0	127	102	0	35	34	35
2025	10	21	8	22	15	26.7	-3.3	1.137	0.4	0.3	0	39.6	29.7	0	127	102	0	35	33	34
2025	10	21	8	32	15	28.3	-2.1	1.136	0.3	0.2	0	40	28.8	0	127	101	0	34	34	34
2025	10	21	8	42	15	26.8	-3.1	1.137	0.3	0.2	0	40	29.2	0	127	101	0	34	33	35
2025	10	21	8	52	15	26.8	-2.8	1.136	0.3	0.2	0	39.1	28.8	0	126	101	0	35	34	34
2025	10	21	9	2	15	28.5	-2.5	1.136	0.3	0.2	0	39.1	29.2	0	126	101	0	35	33	35
2025	10	21	9	12	15	28.2	-3.7	1.136	0.3	0.2	0	40.4	29.2	0	128	102	0	34	34	34
2025	10	21	9	22	15	28.5	-2.4	1.136	0.4	0.3	0	39.1	29.2	0	126	101	0	35	33	34
2025	10	21	9	32	15	28.6	-2.3	1.136	0.3	0.2	0	38.7	29.2	0	125	101	0	35	33	34
2025	10	21	9	42	15	28.8	-3.7	1.136	0.4	0.3	0	38.7	29.2	0	125	101	0	35	33	35
2025	10	21	9	52	15	28.4	-2.9	1.136	0.3	0.2	0	39.6	29.2	0	126	101	0	34	33	35
2025	10	21	10	2	15	27.7	-3.2	1.136	0.4	0.3	0	39.1	28.8	0	126	101	0	35	34	34
2025	10	21	10	12	15	28.7	-1.9	1.136	0.3	0.2	0	39.6	28.8	0	126	101	0	34	34	35
2025	10	21	10	22	15	28.2	-3.3	1.135	0.4	0.3	0	39.1	29.2	0	125	101	0	34	33	35
2025	10	21	10	32	15	27.7	-2.9	1.136	0.3	0.2	0	39.1	28.8	0	125	101	0	34	34	34
2025	10	21	10	42	15	27.6	-3.4	1.135	0.3	0.2	0	39.1	29.7	0	126	102	0	35	33	35
2025	10	21	10	52	15	28.5	-2.4	1.135	0.4	0.3	0	39.1	29.7	0	126	102	0	35	33	34
2025	10	21	11	2	15	26.9	-3.8	1.135	0.3	0.2	0	39.1	29.2	0	126	102	0	35	34	35
2025	10	21	11	12	15	28	-3.3	1.135	0.3	0.2	0	39.1	30.1	0	126	103	0	35	33	34
2025	10	21	11	22	15	28.2	-3.8	1.135	0.4	0.3	0	39.6	29.7	0	126	102	0	34	33	35
2025	10	21	11	32	15	28.1	-2.9	1.135	0.4	0.3	0	39.6	28.8	0	126	101	0	34	34	34
2025	10	21	11	42	15	27.7	-3	1.134	0.3	0.2	0	39.1	28.4	0	126	100	0	35	34	34
2025	10	21	11	52	15	27.3	-3.5	1.134	0.4	0.3	0	39.6	28.8	0	126	101	0	34	34	34
2025	10	21	12	2	15	28.3	-4.1	1.134	0.4	0.3	0	39.1	28	0	125	99	0	34	34	34
2025	10	21	12	12	15	27.3	-4	1.134	0.4	0.3	0	39.1	28.8	0	125	100	0	34	33	34
2025	10	21	12	22	15	27.7	-3.5	1.133	0.3	0.2	0	39.1	28.8	0	125	100	0	34	33	34
2025	10	21	12	32	15	27.3	-3.4	1.133	0.5	0.5	0	38.7	28.4	0	124	99	0	34	33	34
2025	10	21	12	42	15	27.9	-4	1.133	0.3	0.2	0	38.7	28.4	0	125	100	0	35	34	34
2025	10	21	12	52	15	26.8	-3.5	1.131	0.3	0.2	0	38.7	28.8	0	125	100	0	35	33	34
2025	10	21	13	2	15	27	-3.9	1.129	0.3	0.2	0	38.7	29.2	0	125	101	0	35	33	35
2025	10	21	13	12	15	27.4	-3.8	1.129	0.4	0.3	0	40	29.2	0	127	101	0	34	33	35
2025	10	21	13	22	15	27.6	-3.2	1.128	0.3	0.2	0	39.6	29.2	0	126	101	0	34	33	34
2025	10	21	13	32	15	27.2	-3.1	1.128	0.4	0.3	0	38.7	29.2	0	125	101	0	35	33	34
2025	10	21	13	42	15	28	-2.9	1.128	0.3	0.2	0	39.1	28.8	0	126	101	0	35	34	34
2025	10	21	13	52	15	26.6	-2.5	1.127	0.3	0.2	0	39.6	28.8	0	126	101	0	34	34	34
2025	10	21	14	2	15	26.2	-3.1	1.127	0.4	0.3	0	39.6	28.4	0	126	100	0	34	34	33
2025	10	21	14	12	15	28.7	-3.4	1.127	0.3	0.2	0	39.6	29.2	0	126	101	0	34	33	35
2025	10	21	14	22	15	27.6	-2.9	1.127	0.3	0.2	0	39.6	29.2	0	126	101	0	34	33	34
2025	10	21	14	32	15	28.2	-3.7	1.126	0.3	0.2	0	39.1	28.4	0	125	100	0	34	34	34
2025	10	21	14	42	15	27.6	-3.8	1.126	0.4	0.3	0	39.1	29.2	0	125	101	0	34	33	35
2025	10	21	14	52	15	27.5	-2.5	1.126	0.5	0.4	0	39.1	29.2	0	126	101	0	35	33	33
2025	10	21	15	2	15	27.7	-3.4	1.125	0.3	0.2	0	39.6	29.2	0	126	101	0	34	33	34
2025	10	21	15	12	15	27	-3.6	1.125	0.3	0.2	0	39.1	28.8	0	126	101	0	35	34	34
2025	10	21	15	22	15	26.7	-2.6	1.125	0.5	0.4	0	39.1	29.2	0	126	101	0	35	33	34
2025	10	21	15	32	15	27.4	-2.5	1.125	0.3	0.2	0	39.1	29.2	0	126	101	0	35	33	34
2025	10	21	15	42	15	27.5	-3.3	1.124	0.3	0.2	0	40	29.2	0	127	102	0	34	34	34
2025	10	21	15	52	15	27.4	-3.7	1.124	0.4	0.3	0	40	29.7	0	127	102	0	34	33	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	21	16	2	15	26.8	-3	1.124	0.4	0.3	0	40.4	29.7	0	128	103	0	34	34	34
2025	10	21	16	12	15	26.8	-3.5	1.123	0.4	0.3	0	40.4	30.1	0	128	103	0	34	33	35
2025	10	21	16	22	15	26.6	-3	1.123	0.5	0.4	0	40	30.1	0	128	104	0	35	34	35
2025	10	21	16	32	15	28.1	-3.2	1.123	0.3	0.2	0	39.6	29.7	0	127	102	0	35	33	35
2025	10	21	16	42	15	26.1	-2.9	1.123	0.4	0.3	0	40.4	29.7	0	128	102	0	34	33	34
2025	10	21	16	52	15	27.4	-2.8	1.122	0.3	0.2	0	40	29.2	0	127	102	0	34	34	35
2025	10	21	17	2	15	27.6	-2.4	1.122	0.4	0.3	0	40	29.2	0	127	101	0	34	33	35
2025	10	21	17	12	15	26.5	-2.7	1.121	0.3	0.2	0	40	29.2	0	128	102	0	35	34	35
2025	10	21	17	22	15	27.3	-3.8	1.121	0.4	0.3	0	40.4	30.1	0	128	103	0	34	33	34
2025	10	21	17	32	15	27.2	-2.5	1.121	0.4	0.3	0	40.4	30.1	0	129	103	0	35	33	34
2025	10	21	17	42	15	28.4	-2.5	1.121	0.3	0.2	0	40	29.7	0	128	102	0	35	33	34
2025	10	21	17	52	15	27.9	-3	1.12	0.5	0.4	0	40.4	29.7	0	128	102	0	34	33	35
2025	10	21	18	2	15	28.5	-3.7	1.118	0.4	0.3	0	40	29.7	0	128	102	0	35	33	33
2025	10	21	18	12	15	26.6	-1.7	1.117	0.4	0.3	0	40.4	30.1	0	129	103	0	35	33	34
2025	10	21	18	22	15	28	-3.9	1.116	0.3	0.2	0	40.4	29.7	0	128	102	0	34	33	34
2025	10	21	18	32	15	27	-3.1	1.116	0.5	0.4	0	40.9	30.5	0	130	104	0	35	33	34
2025	10	21	18	42	15	28.2	-3.1	1.116	0.4	0.3	0	40.9	30.1	0	130	104	0	35	34	34
2025	10	21	18	52	15	28	-3.4	1.115	0.5	0.4	0	41.3	31	0	131	106	0	35	34	34
2025	10	21	19	2	15	28.3	-3.1	1.115	0.3	0.2	0	42.1	31	0	132	105	0	34	33	34
2025	10	21	19	12	15	27.7	-4.2	1.115	0.5	0.4	0	42.1	31.4	0	132	106	0	34	33	34
2025	10	21	19	22	15	27.6	-2.9	1.115	0.3	0.2	0	42.1	30.5	0	132	105	0	34	34	34
2025	10	21	19	32	15	26.8	-3	1.114	0.4	0.3	0	42.1	31	0	132	105	0	34	33	34
2025	10	21	19	42	15	26.8	-2.4	1.114	0.4	0.3	0	41.7	31.4	0	132	106	0	35	33	34
2025	10	21	19	52	15	26.4	-3.2	1.114	0.4	0.3	0	42.1	31.4	0	133	106	0	35	33	34
2025	10	21	20	2	15	27.8	-2.9	1.114	0.4	0.3	0	42.6	31.8	0	134	107	0	35	33	34
2025	10	21	20	12	15	27.8	-2.5	1.113	0.5	0.4	0	42.1	31.8	0	133	107	0	35	33	34
2025	10	21	20	22	15	27.6	-3.5	1.113	0.4	0.3	0	42.1	31.4	0	133	107	0	35	34	35
2025	10	21	20	32	15	27.6	-3.4	1.113	0.3	0.2	0	42.6	31.4	0	133	106	0	34	33	34
2025	10	21	20	42	15	27.1	-2.9	1.113	0.4	0.3	0	41.7	31.4	0	132	106	0	35	33	34
2025	10	21	20	52	15	26.4	-2.6	1.113	0.3	0.2	0	41.7	31	0	132	106	0	35	34	34
2025	10	21	21	2	15	26.8	-2.9	1.112	0.4	0.3	0	42.6	31.4	0	133	107	0	34	34	34
2025	10	21	21	12	15	26.6	-3.2	1.112	0.5	0.4	0	42.1	31.8	0	133	107	0	35	33	34
2025	10	21	21	22	15	26.6	-1.7	1.112	0.4	0.3	0	42.6	31.4	0	134	107	0	35	34	34
2025	10	21	21	32	15	26.4	-3	1.112	0.5	0.4	0	42.6	31	0	133	106	0	34	34	35
2025	10	21	21	42	15	27.8	-4.1	1.112	0.3	0.2	0	43	31.4	0	134	107	0	34	34	34
2025	10	21	21	52	15	27.4	-2.5	1.111	0.5	0.5	0	43	31.4	0	135	107	0	35	34	35
2025	10	21	22	2	15	28	-2.9	1.111	0.4	0.3	0	42.6	31.8	0	134	107	0	35	33	34
2025	10	21	22	12	15	26	-3.3	1.111	0.5	0.4	0	43	32.3	0	134	107	0	34	32	34
2025	10	21	22	22	15	26.4	-2.9	1.111	0.3	0.2	0	43.4	31.8	0	135	107	0	34	33	34
2025	10	21	22	32	15	28.1	-2.8	1.11	0.4	0.3	0	42.6	31.4	0	134	107	0	35	34	35
2025	10	21	22	42	15	27.6	-2.3	1.11	0.5	0.4	0	43	31.4	0	134	107	0	34	34	34
2025	10	21	22	52	15	27.6	-2.9	1.11	0.4	0.3	0	42.1	31.4	0	133	106	0	35	33	34
2025	10	21	23	2	15	27.2	-3.7	1.109	0.3	0.2	0	42.6	31	0	134	106	0	35	34	34
2025	10	21	23	12	15	27.4	-2.4	1.109	0.4	0.3	0	42.6	31.4	0	134	107	0	35	34	34
2025	10	21	23	22	15	28	-2.6	1.109	0.4	0.3	0	43	31.8	0	134	107	0	34	33	34
2025	10	21	23	32	15	28.5	-2.9	1.109	0.4	0.3	0	43.4	31.4	0	135	107	0	34	34	34
2025	10	21	23	42	15	27.2	-3.5	1.108	0.3	0.2	0	43.4	31.4	0	135	107	0	34	34	34
2025	10	21	23	52	15	27.1	-3.2	1.108	0.4	0.3	0	43	31	0	135	106	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	22	0	2	15	28	-3.4	1.107	0.3	0.2	0	42.1	31	0	133	106	0	35	34	34
2025	10	22	0	12	15	27.1	-3.3	1.106	0.3	0.2	0	43	31.4	0	135	107	0	35	34	34
2025	10	22	0	22	15	28.2	-2.2	1.105	0.4	0.3	0	43	31.8	0	134	107	0	34	33	35
2025	10	22	0	32	15	27.6	-3.5	1.104	0.3	0.2	0	42.6	31	0	134	106	0	35	34	35
2025	10	22	0	42	15	28.2	-3.7	1.104	0.3	0.2	0	42.1	30.5	0	133	105	0	35	34	34
2025	10	22	0	52	15	27.5	-2.9	1.103	0.3	0.2	0	42.1	31	0	133	106	0	35	34	34
2025	10	22	1	2	15	27.1	-2.4	1.103	0.4	0.3	0	42.6	31.4	0	134	106	0	35	33	34
2025	10	22	1	12	15	27.8	-3.8	1.103	0.3	0.2	0	42.1	31.4	0	133	106	0	35	33	35
2025	10	22	1	22	15	25.9	-1.9	1.103	0.4	0.3	0	42.6	28.8	0	134	100	0	35	33	34
2025	10	22	1	32	15	26.9	-3	1.103	0.4	0.3	0	42.6	31.8	0	134	107	0	35	33	35
2025	10	22	1	42	15	25.8	-2.2	1.102	0.4	0.3	0	43	31.8	0	134	107	0	34	33	34
2025	10	22	1	52	15	27.5	-3.8	1.102	0.3	0.2	0	42.1	31	0	133	106	0	35	34	34
2025	10	22	2	2	15	25.6	-3.2	1.102	0.3	0.2	0	42.6	31	0	134	106	0	35	34	34
2025	10	22	2	12	15	26.8	-2.7	1.102	0.4	0.3	0	43	31.8	0	134	107	0	34	33	34
2025	10	22	2	22	15	26.6	-3.8	1.102	0.4	0.3	0	42.6	31.4	0	134	106	0	35	33	35
2025	10	22	2	32	15	28.3	-3.6	1.101	0.4	0.3	0	42.6	31.4	0	133	106	0	34	33	35
2025	10	22	2	42	15	26.9	-2.9	1.101	0.5	0.4	0	42.6	31.8	0	134	107	0	35	33	34
2025	10	22	2	52	15	26.8	-3.4	1.101	0.4	0.3	0	42.6	31	0	134	106	0	35	34	34
2025	10	22	3	2	15	26.5	-2.7	1.101	0.5	0.4	0	42.6	31.8	0	134	107	0	35	33	35
2025	10	22	3	12	15	27.4	-2.9	1.101	0.5	0.4	0	43	31.4	0	135	107	0	35	34	34
2025	10	22	3	22	15	27.9	-2.7	1.101	0.3	0.2	0	42.6	31.4	0	134	106	0	35	33	35
2025	10	22	3	32	15	26.8	-2.9	1.101	0.4	0.3	0	42.6	31.4	0	134	107	0	35	34	35
2025	10	22	3	42	15	26.5	-3.8	1.1	0.4	0.3	0	43	31.4	0	134	106	0	34	33	35
2025	10	22	3	52	15	27.3	-3.2	1.1	0.3	0.2	0	43	31.4	0	134	106	0	34	33	34
2025	10	22	4	2	15	26.8	-2.5	1.1	0.3	0.2	0	42.6	31.4	0	134	106	0	35	33	34
2025	10	22	4	12	15	25.2	-2.6	1.1	0.4	0.3	0	42.1	31.4	0	132	106	0	34	33	33
2025	10	22	4	22	15	26.6	-2.5	1.1	0.5	0.4	0	42.6	31.4	0	134	107	0	35	34	34
2025	10	22	4	32	15	26.9	-2.6	1.1	0.3	0.2	0	43	31.8	0	134	107	0	34	33	34
2025	10	22	4	42	15	27.3	-2.9	1.1	0.4	0.3	0	42.6	31	0	134	106	0	35	34	35
2025	10	22	4	52	15	25.4	-2	1.099	0.4	0.3	0	43	32.3	0	135	108	0	35	33	34
2025	10	22	5	2	15	26.9	-3.1	1.1	0.5	0.4	0	42.6	31.8	0	134	107	0	35	33	35
2025	10	22	5	12	15	27.7	-2.8	1.099	0.5	0.4	0	43	31.4	0	134	106	0	34	33	34
2025	10	22	5	22	15	27.2	-2.6	1.099	0.4	0.3	0	43	31.4	0	134	106	0	34	33	34
2025	10	22	5	32	15	27.1	-2.9	1.098	0.4	0.3	0	43	31.8	0	134	107	0	34	33	34
2025	10	22	5	42	15	26.5	-3.3	1.098	0.4	0.3	0	42.6	31.8	0	134	107	0	35	33	34
2025	10	22	5	52	15	27.3	-3.2	1.098	0.5	0.4	0	42.6	31	0	133	106	0	34	34	35
2025	10	22	6	2	15	28.2	-2.8	1.098	0.3	0.2	0	43	31.4	0	134	106	0	34	33	34
2025	10	22	6	12	15	26.1	-2.2	1.098	0.4	0.3	0	42.1	31.4	0	133	106	0	35	33	33
2025	10	22	6	22	15	26.4	-2.1	1.097	0.3	0.2	0	42.6	31.4	0	133	106	0	34	33	34
2025	10	22	6	32	15	26.5	-2.1	1.095	0.4	0.3	0	43	31.4	0	134	107	0	34	34	33
2025	10	22	6	42	15	27.9	-3.5	1.094	0.3	0.2	0	42.6	31	0	133	105	0	34	33	34
2025	10	22	6	52	15	27.2	-2	1.094	0.5	0.4	0	43	31	0	134	106	0	34	34	34
2025	10	22	7	2	15	26.9	-3.4	1.094	0.4	0.3	0	42.1	31	0	133	105	0	35	33	34
2025	10	22	7	12	15	29	-3.4	1.093	0.5	0.4	0	42.1	30.1	0	132	104	0	34	34	34
2025	10	22	7	22	15	26.9	-3.6	1.093	0.5	0.4	0	42.1	31	0	133	105	0	35	33	33
2025	10	22	7	32	15	27.3	-2.4	1.093	0.3	0.2	0	41.7	31	0	132	105	0	35	33	34
2025	10	22	7	42	15	27.4	-2.9	1.093	0.5	0.4	0	41.7	30.1	0	131	103	0	34	33	33
2025	10	22	7	52	15	26.1	-3.2	1.093	0.3	0.2	0	41.3	30.1	0	131	103	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	22	8	2	15	26.9	-4.2	1.093	0.3	0.2	0	40.9	29.7	0	130	102	0	35	33	35
2025	10	22	8	12	15	26.4	-2.6	1.093	0.5	0.4	0	40.9	29.7	0	129	103	0	34	34	34
2025	10	22	8	22	15	25.4	-1.7	1.092	0.4	0.3	0	41.3	29.7	0	131	103	0	35	34	34
2025	10	22	8	32	15	26.8	-2.9	1.092	0.3	0.2	0	40.9	29.2	0	130	102	0	35	34	34
2025	10	22	8	42	15	26.7	-3	1.092	0.4	0.3	0	40.9	29.7	0	130	102	0	35	33	35
2025	10	22	8	52	15	26.2	-2.8	1.092	0.4	0.3	0	41.7	29.7	0	131	102	0	34	33	34
2025	10	22	9	2	15	27.6	-2.7	1.092	0.3	0.2	0	41.3	29.7	0	130	102	0	34	33	34
2025	10	22	9	12	15	27.6	-2.5	1.092	0.4	0.3	0	40.4	29.2	0	129	101	0	35	33	34
2025	10	22	9	22	15	27.2	-2.5	1.092	0.4	0.3	0	41.3	29.2	0	130	102	0	34	34	34
2025	10	22	9	32	15	26.6	-2.8	1.091	0.4	0.3	0	41.3	29.7	0	130	102	0	34	33	34
2025	10	22	9	42	15	25.5	-3.7	1.092	0.4	0.3	0	40.9	29.7	0	129	102	0	34	33	34
2025	10	22	9	52	15	25.8	-2	1.091	0.3	0.2	0	40.9	31.4	0	129	105	0	34	32	34
2025	10	22	10	2	15	24	-0.9	1.091	0.3	0.2	0	40.9	31	0	129	105	0	34	33	34
2025	10	22	10	12	15	26	-0.8	1.091	0.4	0.3	0	40.9	30.5	0	129	104	0	34	33	34
2025	10	22	10	22	15	25.8	-1.9	1.091	0.3	0.2	0	40.9	31	0	129	105	0	34	33	34
2025	10	22	10	32	15	24.9	-1.2	1.091	0.4	0.3	0	40.9	30.1	0	129	104	0	34	34	34
2025	10	22	10	42	15	25.1	-1.5	1.091	0.3	0.2	0	40.4	30.5	0	128	104	0	34	33	34
2025	10	22	10	52	15	24.6	-1.8	1.091	0.3	0.2	0	40.9	30.5	0	130	105	0	35	34	34
2025	10	22	11	2	15	25.8	-1	1.091	0.3	0.2	0	40.4	31	0	129	105	0	35	33	34
2025	10	22	11	12	15	24.2	-1.1	1.091	0.4	0.3	0	40.9	31	0	129	105	0	34	33	34
2025	10	22	11	22	15	25	-1.3	1.091	0.4	0.3	0	40.4	31	0	128	105	0	34	33	33
2025	10	22	11	32	15	25.2	-2.6	1.091	0.4	0.3	0	40.9	31	0	130	106	0	35	34	34
2025	10	22	11	42	15	25.2	-1.6	1.091	0.4	0.3	0	40.9	31	0	130	106	0	35	34	34
2025	10	22	11	52	15	24.7	-0.8	1.091	0.4	0.3	0	40.9	31.4	0	130	106	0	35	33	34
2025	10	22	12	2	15	24.5	-1.3	1.091	0.4	0.3	0	41.3	32.7	0	131	109	0	35	33	34
2025	10	22	12	12	15	24.7	-1.2	1.091	0.3	0.2	0	41.7	31.8	0	131	108	0	34	34	34
2025	10	22	12	22	15	24.9	-1.6	1.09	0.5	0.5	0	42.1	32.7	0	132	109	0	34	33	34
2025	10	22	12	32	15	25.2	-2.1	1.09	0.3	0.2	0	41.3	31	0	131	106	0	35	34	35
2025	10	22	12	42	15	26	-1.1	1.09	0.4	0.3	0	41.7	31.8	0	131	107	0	34	33	34
2025	10	22	12	52	15	26.5	-1.9	1.089	0.5	0.4	0	40.9	31	0	129	105	0	34	33	34
2025	10	22	13	2	15	25.4	-1.7	1.09	0.4	0.3	0	41.3	31	0	130	105	0	34	33	34
2025	10	22	13	12	15	25.6	-1.3	1.089	0.3	0.2	0	41.7	31.4	0	131	107	0	34	34	34
2025	10	22	13	22	15	25.3	-2	1.089	0.3	0.2	0	40.4	31	0	129	105	0	35	33	34
2025	10	22	13	32	15	26.3	-2.1	1.089	0.4	0.3	0	41.7	31.4	0	131	106	0	34	33	34
2025	10	22	13	42	15	26	-2.1	1.088	0.5	0.4	0	40.4	31	0	129	105	0	35	33	34
2025	10	22	13	52	15	26.4	-1.7	1.086	0.4	0.3	0	40.9	31	0	129	105	0	34	33	34
2025	10	22	14	2	15	26.3	-2.3	1.085	0.3	0.2	0	41.3	31.8	0	131	107	0	35	33	34
2025	10	22	14	12	15	25.7	-2.7	1.086	0.4	0.3	0	41.3	31	0	130	106	0	34	34	34
2025	10	22	14	22	15	25.2	-2.6	1.085	0.5	0.5	0	42.1	31.8	0	132	107	0	34	33	34
2025	10	22	14	32	15	25.3	-2.8	1.085	0.5	0.4	0	41.3	31.4	0	131	106	0	35	33	34
2025	10	22	14	42	15	24.4	-2.4	1.084	0.4	0.3	0	41.7	31.8	0	131	106	0	34	32	34
2025	10	22	14	52	15	26.4	-3	1.084	0.3	0.2	0	41.3	31.4	0	131	106	0	35	33	33
2025	10	22	15	2	15	25.1	-3	1.084	0.3	0.2	0	42.1	32.3	0	132	108	0	34	33	34
2025	10	22	15	12	15	25.9	-2.5	1.083	0.4	0.3	0	41.7	31.8	0	131	107	0	34	33	34
2025	10	22	15	22	15	27.4	-2.5	1.083	0.4	0.3	0	42.6	32.3	0	133	108	0	34	33	34
2025	10	22	15	32	15	25.1	-2.2	1.083	0.5	0.4	0	42.6	32.7	0	133	109	0	34	33	34
2025	10	22	15	42	15	27	-1.9	1.083	0.5	0.4	0	42.6	33.1	0	133	109	0	34	32	33
2025	10	22	15	52	15	26.8	-2.2	1.083	0.5	0.4	0	43	32.7	0	134	109	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	22	16	2	15	24.7	-2.4	1.083	0.4	0.3	0	42.1	31.8	0	132	107	0	34	33	34
2025	10	22	16	12	15	25.7	-2.6	1.083	0.4	0.3	0	42.1	32.3	0	133	108	0	35	33	34
2025	10	22	16	22	15	26.1	-2.3	1.082	0.5	0.4	0	42.6	31.8	0	133	108	0	34	34	33
2025	10	22	16	32	15	26.8	-2.5	1.082	0.5	0.4	0	42.1	31.8	0	132	107	0	34	33	33
2025	10	22	16	42	15	25.3	-2.8	1.082	0.4	0.3	0	42.6	32.7	0	133	109	0	34	33	34
2025	10	22	16	52	15	25.5	-2.7	1.081	0.3	0.2	0	42.1	31.8	0	132	107	0	34	33	33
2025	10	22	17	2	15	25.7	-1.7	1.081	0.4	0.3	0	42.1	31.8	0	132	107	0	34	33	34
2025	10	22	17	12	15	25.6	-2.2	1.081	0.4	0.3	0	41.7	31.4	0	131	106	0	34	33	34
2025	10	22	17	22	15	25.1	-2.8	1.081	0.3	0.2	0	41.7	31	0	131	106	0	34	34	33
2025	10	22	17	32	15	26.8	-1.7	1.081	0.5	0.4	0	42.1	32.3	0	132	108	0	34	33	34
2025	10	22	17	42	15	26.7	-2.5	1.081	0.4	0.3	0	41.7	32.7	0	132	108	0	35	32	34
2025	10	22	17	52	15	27.2	-2.5	1.081	0.5	0.4	0	42.1	31.8	0	132	107	0	34	33	34
2025	10	22	18	2	15	25.9	-3.6	1.08	0.5	0.4	0	42.1	31.8	0	132	107	0	34	33	34
2025	10	22	18	12	15	25.6	-2.2	1.08	0.4	0.3	0	42.1	31.8	0	132	107	0	34	33	34
2025	10	22	18	22	15	26.6	-2.8	1.08	0.5	0.5	0	42.1	31.4	0	132	107	0	34	34	34
2025	10	22	18	32	15	25	-2.6	1.08	0.3	0.2	0	42.6	32.7	0	133	108	0	34	32	34
2025	10	22	18	42	15	25.5	-3.2	1.08	0.5	0.4	0	42.1	31.8	0	132	107	0	34	33	34
2025	10	22	18	52	15	26.1	-2.8	1.08	0.4	0.3	0	42.1	32.3	0	133	108	0	35	33	34
2025	10	22	19	2	15	26.6	-3.1	1.08	0.5	0.4	0	42.6	32.3	0	133	108	0	34	33	34
2025	10	22	19	12	15	26.4	-2.5	1.08	0.5	0.4	0	42.1	32.3	0	133	108	0	35	33	34
2025	10	22	19	22	15	25.8	-2.8	1.08	0.5	0.5	0	42.6	32.3	0	133	108	0	34	33	34
2025	10	22	19	32	15	26.9	-3.6	1.08	0.3	0.2	0	42.6	32.7	0	133	109	0	34	33	34
2025	10	22	19	42	15	26.3	-2.1	1.08	0.4	0.3	0	43	33.1	0	135	110	0	35	33	34
2025	10	22	19	52	15	25.9	-1.9	1.08	0.5	0.4	0	43.4	33.1	0	135	110	0	34	33	35
2025	10	22	20	2	15	27.7	-3.3	1.08	0.5	0.4	0	42.6	32.7	0	134	109	0	35	33	33
2025	10	22	20	12	15	25.8	-2.5	1.08	0.3	0.2	0	42.6	33.1	0	134	110	0	35	33	34
2025	10	22	20	22	15	25.8	-3.2	1.08	0.4	0.3	0	43.4	33.1	0	135	110	0	34	33	34
2025	10	22	20	32	15	25.8	-3.2	1.08	0.5	0.4	0	43	32.7	0	134	110	0	34	34	34
2025	10	22	20	42	15	27.2	-2.1	1.079	0.3	0.2	0	43	33.1	0	135	110	0	35	33	34
2025	10	22	20	52	15	26.6	-2.5	1.08	0.4	0.3	0	43	32.7	0	135	109	0	35	33	34
2025	10	22	21	2	15	25.8	-2.1	1.079	0.5	0.5	0	43.4	33.1	0	135	110	0	34	33	34
2025	10	22	21	12	15	26.7	-2.5	1.079	0.5	0.4	0	43.4	33.1	0	135	110	0	34	33	34
2025	10	22	21	22	15	26.4	-3	1.079	0.3	0.2	0	42.6	32.7	0	134	110	0	35	34	34
2025	10	22	21	32	15	27.3	-2.5	1.079	0.4	0.3	0	43.4	33.1	0	135	110	0	34	33	35
2025	10	22	21	42	15	26	-3.5	1.079	0.5	0.4	0	43	33.1	0	135	110	0	35	33	34
2025	10	22	21	52	15	27.3	-2.7	1.079	0.4	0.3	0	43.4	33.1	0	135	110	0	34	33	34
2025	10	22	22	2	15	26.8	-2.5	1.079	0.6	0.5	0	43.4	33.1	0	135	110	0	34	33	34
2025	10	22	22	12	15	27.5	-2.2	1.079	0.4	0.3	0	43	33.1	0	134	110	0	34	33	34
2025	10	22	22	22	15	26.3	-3	1.079	0.3	0.2	0	43	33.1	0	134	110	0	34	33	34
2025	10	22	22	32	15	25.8	-2.2	1.079	0.5	0.4	0	43.4	32.7	0	135	110	0	34	34	33
2025	10	22	22	42	15	26.5	-1.9	1.079	0.3	0.2	0	43.4	32.7	0	135	110	0	34	34	34
2025	10	22	22	52	15	25.1	-3.3	1.079	0.4	0.3	0	43	33.1	0	134	110	0	34	33	34
2025	10	22	23	2	15	24.9	-1.8	1.078	0.4	0.3	0	43.4	33.1	0	135	110	0	34	33	34
2025	10	22	23	12	15	26.8	-2.5	1.078	0.4	0.3	0	43	33.1	0	134	110	0	34	33	34
2025	10	22	23	22	15	26.7	-2.4	1.078	0.4	0.3	0	42.6	33.1	0	134	110	0	35	33	34
2025	10	22	23	32	15	26.3	-2.5	1.078	0.4	0.3	0	42.6	33.1	0	133	110	0	34	33	34
2025	10	22	23	42	15	27.1	-3.4	1.078	0.3	0.2	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	22	23	52	15	26.8	-1.7	1.078	0.5	0.4	0	43	33.1	0	134	110	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	23	0	2	15	26.2	-2.8	1.078	0.4	0.3	0	42.6	32.7	0	134	110	0	35	34	35
2025	10	23	0	12	15	25.9	-2.8	1.078	0.5	0.5	0	43	32.7	0	135	110	0	35	34	34
2025	10	23	0	22	15	26.3	-1.8	1.078	0.5	0.4	0	42.6	32.7	0	134	110	0	35	34	34
2025	10	23	0	32	15	26.5	-3.4	1.078	0.4	0.3	0	43	33.1	0	134	110	0	34	33	34
2025	10	23	0	42	15	27.1	-2.5	1.078	0.4	0.3	0	43.4	33.1	0	135	110	0	34	33	34
2025	10	23	0	52	15	25.8	-2.8	1.077	0.3	0.2	0	43	33.5	0	135	111	0	35	33	34
2025	10	23	1	2	15	27.3	-2.5	1.077	0.4	0.3	0	42.6	33.1	0	134	110	0	35	33	34
2025	10	23	1	12	15	25.8	-2.9	1.077	0.4	0.3	0	43	33.1	0	134	110	0	34	33	34
2025	10	23	1	22	15	25.5	-2.7	1.077	0.5	0.4	0	42.6	33.1	0	134	110	0	35	33	34
2025	10	23	1	32	15	25.1	-3.3	1.077	0.5	0.5	0	43	33.5	0	134	111	0	34	33	35
2025	10	23	1	42	15	26	-2.7	1.077	0.3	0.2	0	44.3	33.5	0	137	111	0	34	33	34
2025	10	23	1	52	15	27.5	-2.9	1.077	0.4	0.3	0	44.3	33.5	0	137	111	0	34	33	34
2025	10	23	2	2	15	26.5	-3.2	1.077	0.4	0.3	0	44.3	33.5	0	137	111	0	34	33	35
2025	10	23	2	12	15	26.9	-2.6	1.077	0.3	0.2	0	43.9	33.5	0	136	111	0	34	33	34
2025	10	23	2	22	15	26.6	-2	1.077	0.4	0.3	0	43.4	33.5	0	136	111	0	35	33	34
2025	10	23	2	32	15	27.2	-3.1	1.077	0.4	0.3	0	43.9	33.1	0	136	110	0	34	33	34
2025	10	23	2	42	15	26.4	-2.8	1.077	0.4	0.3	0	43.4	33.1	0	136	111	0	35	34	34
2025	10	23	2	52	15	26.1	-3.3	1.076	0.5	0.4	0	43.9	33.5	0	137	111	0	35	33	34
2025	10	23	3	2	15	27.4	-3.6	1.076	0.4	0.3	0	43.9	33.1	0	136	110	0	34	33	34
2025	10	23	3	12	15	25.8	-2.7	1.076	0.3	0.2	0	43.4	34	0	136	111	0	35	32	34
2025	10	23	3	22	15	27.3	-3.2	1.076	0.4	0.3	0	43.9	33.5	0	136	111	0	34	33	34
2025	10	23	3	32	15	27.3	-3.4	1.076	0.3	0.2	0	43.4	33.5	0	136	111	0	35	33	34
2025	10	23	3	42	15	26.9	-2.5	1.076	0.4	0.3	0	43.9	33.5	0	137	111	0	35	33	34
2025	10	23	3	52	15	26.7	-2.7	1.076	0.4	0.3	0	43.9	33.5	0	136	111	0	34	33	35
2025	10	23	4	2	15	27.1	-3.4	1.075	0.3	0.2	0	43.4	33.5	0	136	111	0	35	33	34
2025	10	23	4	12	15	27.7	-3	1.075	0.4	0.3	0	43.4	33.1	0	135	110	0	34	33	34
2025	10	23	4	22	15	25.5	-3.2	1.075	0.4	0.3	0	42.6	33.1	0	133	111	0	34	34	34
2025	10	23	4	32	15	27.4	-2.1	1.075	0.5	0.4	0	44.3	33.5	0	137	111	0	34	33	34
2025	10	23	4	42	15	27.6	-3	1.074	0.4	0.3	0	43.9	32.7	0	136	110	0	34	34	33
2025	10	23	4	52	15	25.5	-3.2	1.075	0.4	0.3	0	42.6	32.7	0	133	109	0	34	33	34
2025	10	23	5	2	15	25.4	-3	1.074	0.3	0.2	0	44.3	34	0	137	111	0	34	32	34
2025	10	23	5	12	15	26.1	-2.8	1.074	0.4	0.3	0	43.9	33.5	0	136	111	0	34	33	34
2025	10	23	5	22	15	28	-2.5	1.073	0.4	0.3	0	44.3	33.5	0	136	111	0	33	33	34
2025	10	23	5	32	15	26.7	-2.9	1.072	0.3	0.2	0	43.9	33.5	0	136	111	0	34	33	34
2025	10	23	5	42	15	26.4	-2.6	1.072	0.4	0.3	0	43.9	34	0	136	112	0	34	33	34
2025	10	23	5	52	15	27.2	-2.2	1.072	0.3	0.2	0	43.4	33.1	0	135	111	0	34	34	34
2025	10	23	6	2	15	28.4	-2.8	1.072	0.4	0.3	0	43	33.1	0	135	111	0	35	34	34
2025	10	23	6	12	15	25.2	-3.4	1.072	0.3	0.2	0	43.9	33.5	0	136	112	0	34	34	34
2025	10	23	6	22	15	25.8	-2.6	1.072	0.3	0.2	0	43.9	34	0	136	112	0	34	33	33
2025	10	23	6	32	15	27.7	-2	1.072	0.5	0.4	0	43	33.1	0	135	111	0	35	34	34
2025	10	23	6	42	15	27.4	-2.1	1.072	0.3	0.2	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	23	6	52	15	27	-2.5	1.072	0.3	0.2	0	43.4	33.1	0	136	111	0	35	34	34
2025	10	23	7	2	15	26.8	-2.7	1.072	0.3	0.2	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	23	7	12	15	27.6	-3.7	1.072	0.6	0.5	0	43	33.1	0	135	110	0	35	33	34
2025	10	23	7	22	15	27.2	-3.1	1.071	0.5	0.4	0	43.4	33.1	0	135	110	0	34	33	35
2025	10	23	7	32	15	27.6	-3	1.071	0.4	0.3	0	42.6	32.7	0	134	109	0	35	33	34
2025	10	23	7	42	15	25.6	-3.1	1.071	0.3	0.2	0	43	32.7	0	134	109	0	34	33	34
2025	10	23	7	52	15	26.3	-3.4	1.072	0.4	0.3	0	43	32.3	0	134	109	0	34	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	23	8	2	15	26.4	-2.7	1.072	0.3	0.2	0	42.1	32.3	0	133	108	0	35	33	33
2025	10	23	8	12	15	25.9	-2.3	1.071	0.3	0.2	0	43	32.7	0	134	109	0	34	33	34
2025	10	23	8	22	15	25.8	-3.1	1.071	0.5	0.4	0	43	32.7	0	134	110	0	34	34	34
2025	10	23	8	32	15	26.6	-2.3	1.071	0.4	0.3	0	43	32.7	0	134	109	0	34	33	34
2025	10	23	8	42	15	26.5	-2.2	1.071	0.3	0.2	0	43	32.7	0	134	109	0	34	33	35
2025	10	23	8	52	15	26.2	-2.2	1.071	0.4	0.3	0	42.6	32.7	0	133	109	0	34	33	35
2025	10	23	9	2	15	26.5	-2.4	1.071	0.3	0.2	0	42.6	32.7	0	133	109	0	34	33	34
2025	10	23	9	12	15	26.3	-3.1	1.071	0.4	0.3	0	42.1	32.3	0	132	108	0	34	33	34
2025	10	23	9	22	15	25.7	-2.1	1.071	0.4	0.3	0	42.6	32.7	0	133	109	0	34	33	34
2025	10	23	9	32	15	26.7	-3.2	1.071	0.3	0.2	0	42.6	32.7	0	133	109	0	34	33	35
2025	10	23	9	42	15	25.5	-2.5	1.071	0.5	0.4	0	42.1	32.7	0	132	109	0	34	33	35
2025	10	23	9	52	15	25.5	-2	1.071	0.5	0.4	0	42.1	32.3	0	133	109	0	35	34	34
2025	10	23	10	2	15	26.4	-3.1	1.071	0.3	0.2	0	41.7	32.3	0	132	108	0	35	33	34
2025	10	23	10	12	15	26.1	-3	1.071	0.4	0.3	0	41.7	31.8	0	131	107	0	34	33	34
2025	10	23	10	22	15	28.3	-2.7	1.071	0.3	0.2	0	41.7	31.8	0	131	107	0	34	33	33
2025	10	23	10	32	15	26.7	-3.5	1.071	0.3	0.2	0	42.6	32.7	0	133	109	0	34	33	34
2025	10	23	10	42	15	27.4	-3.3	1.071	0.5	0.4	0	42.6	32.3	0	132	108	0	33	33	34
2025	10	23	10	52	15	27.3	-2.1	1.071	0.4	0.3	0	42.1	32.3	0	132	109	0	34	34	34
2025	10	23	11	2	15	26.3	-2.3	1.071	0.4	0.3	0	42.1	33.1	0	133	110	0	35	33	34
2025	10	23	11	12	15	25.4	-1.7	1.071	0.4	0.3	0	43	33.5	0	134	111	0	34	33	34
2025	10	23	11	22	15	25.9	-2.1	1.071	0.5	0.4	0	42.6	34	0	133	111	0	34	32	34
2025	10	23	11	32	15	25.7	-2.2	1.071	0.4	0.3	0	43	33.5	0	134	111	0	34	33	34
2025	10	23	11	42	15	24.8	-2.6	1.071	0.4	0.3	0	42.6	33.1	0	133	110	0	34	33	34
2025	10	23	11	52	15	24.9	-1.1	1.071	0.4	0.3	0	43	33.5	0	134	111	0	34	33	33
2025	10	23	12	2	15	26.5	-2.3	1.071	0.4	0.3	0	42.6	33.1	0	134	111	0	35	34	34
2025	10	23	12	12	15	26.6	-2.9	1.071	0.4	0.3	0	42.6	33.1	0	133	110	0	34	33	34
2025	10	23	12	22	15	27	-2.5	1.071	0.4	0.3	0	42.6	33.1	0	133	110	0	34	33	34
2025	10	23	12	32	15	25.8	-2.8	1.071	0.3	0.2	0	42.1	33.1	0	133	110	0	35	33	34
2025	10	23	12	42	15	25.7	-2.2	1.071	0.5	0.4	0	43	33.1	0	134	111	0	34	34	33
2025	10	23	12	52	15	25.8	-2.1	1.07	0.4	0.3	0	42.1	32.7	0	133	109	0	35	33	34
2025	10	23	13	2	15	25.7	-2.3	1.071	0.5	0.5	0	42.1	33.1	0	132	110	0	34	33	34
2025	10	23	13	12	15	26	-2.8	1.071	0.4	0.3	0	42.1	32.7	0	132	108	0	34	32	34
2025	10	23	13	22	15	26.4	-2.2	1.071	0.3	0.2	0	42.1	32.3	0	132	109	0	34	34	34
2025	10	23	13	32	15	27.3	-2.8	1.07	0.3	0.2	0	42.1	32.3	0	132	108	0	34	33	34
2025	10	23	13	42	15	26.3	-2.8	1.07	0.4	0.3	0	42.1	32.7	0	132	109	0	34	33	34
2025	10	23	13	52	15	25.6	-3.1	1.07	0.3	0.2	0	42.1	31.8	0	132	108	0	34	34	34
2025	10	23	14	2	15	25.4	-2.2	1.07	0.4	0.3	0	42.1	32.7	0	132	109	0	34	33	34
2025	10	23	14	12	15	26.4	-2.6	1.07	0.5	0.4	0	42.1	32.3	0	132	108	0	34	33	34
2025	10	23	14	22	15	25.4	-2.6	1.07	0.5	0.4	0	42.1	33.1	0	132	109	0	34	32	34
2025	10	23	14	32	15	27	-3	1.07	0.3	0.2	0	42.1	32.7	0	132	109	0	34	33	34
2025	10	23	14	42	15	25.7	-2.5	1.07	0.4	0.3	0	41.7	32.7	0	132	109	0	35	33	33
2025	10	23	14	52	15	26.2	-3.4	1.07	0.3	0.2	0	42.1	32.3	0	132	108	0	34	33	34
2025	10	23	15	2	15	27.4	-2.7	1.07	0.4	0.3	0	41.7	31.8	0	131	107	0	34	33	34
2025	10	23	15	12	15	26.5	-2.6	1.07	0.3	0.2	0	42.6	32.3	0	133	109	0	34	34	35
2025	10	23	15	22	15	27.8	-3.3	1.07	0.4	0.3	0	42.1	32.3	0	132	108	0	34	33	33
2025	10	23	15	32	15	26.4	-2.6	1.07	0.4	0.3	0	42.6	32.7	0	132	109	0	33	33	34
2025	10	23	15	42	15	26.8	-2.8	1.069	0.4	0.3	0	42.1	32.7	0	132	109	0	34	33	34
2025	10	23	15	52	15	27.4	-3	1.069	0.5	0.4	0	42.1	32.3	0	132	108	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	23	16	2	15	26.9	-2.2	1.069	0.4	0.3	0	43	33.1	0	134	110	0	34	33	33
2025	10	23	16	12	15	26.6	-2.6	1.069	0.3	0.2	0	42.1	32.7	0	132	109	0	34	33	34
2025	10	23	16	22	15	26.2	-2.1	1.069	0.4	0.3	0	42.1	32.3	0	131	108	0	33	33	34
2025	10	23	16	32	15	26.1	-2.7	1.068	0.3	0.2	0	41.7	32.3	0	132	108	0	35	33	34
2025	10	23	16	42	15	25.7	-2.4	1.068	0.5	0.4	0	42.1	32.7	0	132	109	0	34	33	34
2025	10	23	16	52	15	26.6	-2.2	1.068	0.5	0.5	0	41.7	31.8	0	131	107	0	34	33	34
2025	10	23	17	2	15	26.5	-2.3	1.068	0.4	0.3	0	42.1	32.7	0	132	108	0	34	32	33
2025	10	23	17	12	15	26.6	-2.1	1.068	0.4	0.3	0	41.7	32.3	0	132	108	0	35	33	34
2025	10	23	17	22	15	27	-3.5	1.068	0.3	0.2	0	42.1	32.3	0	132	108	0	34	33	34
2025	10	23	17	32	15	26.4	-3.1	1.068	0.5	0.4	0	41.7	31.8	0	131	107	0	34	33	34
2025	10	23	17	42	15	27.2	-2.6	1.068	0.4	0.3	0	42.1	32.3	0	132	108	0	34	33	34
2025	10	23	17	52	15	26.4	-3.2	1.068	0.3	0.2	0	42.6	32.7	0	133	109	0	34	33	34
2025	10	23	18	2	15	27	-2.1	1.068	0.3	0.2	0	42.1	32.3	0	132	108	0	34	33	34
2025	10	23	18	12	15	24.9	-2.4	1.067	0.3	0.2	0	42.1	32.3	0	133	109	0	35	34	34
2025	10	23	18	22	15	26.5	-2.5	1.067	0.4	0.3	0	42.1	32.7	0	133	109	0	35	33	34
2025	10	23	18	32	15	24.9	-1.9	1.067	0.4	0.3	0	43.9	34	0	136	112	0	34	33	34
2025	10	23	18	42	15	26.3	-4.1	1.067	0.5	0.4	0	43.4	33.5	0	135	111	0	34	33	33
2025	10	23	18	52	15	26.3	-3.3	1.067	0.3	0.2	0	43.4	34	0	135	112	0	34	33	34
2025	10	23	19	2	15	25.2	-2.6	1.067	0.3	0.2	0	44.3	34.4	0	137	113	0	34	33	34
2025	10	23	19	12	15	26.9	-3	1.067	0.5	0.4	0	43.9	34	0	136	112	0	34	33	34
2025	10	23	19	22	15	25.4	-2.7	1.066	0.4	0.3	0	44.7	34.4	0	138	113	0	34	33	34
2025	10	23	19	32	15	25.7	-2	1.067	0.4	0.3	0	44.3	34.4	0	137	113	0	34	33	34
2025	10	23	19	42	15	26	-3.7	1.067	0.4	0.3	0	43.4	34.4	0	136	113	0	35	33	34
2025	10	23	19	52	15	26	-3.1	1.066	0.5	0.4	0	44.3	34.8	0	137	113	0	34	32	34
2025	10	23	20	2	15	25.9	-2.9	1.066	0.3	0.2	0	44.3	34.4	0	137	113	0	34	33	34
2025	10	23	20	12	15	27.4	-3.2	1.066	0.5	0.4	0	43.9	34.8	0	136	113	0	34	32	35
2025	10	23	20	22	15	25.9	-2.9	1.066	0.4	0.3	0	43.9	34.4	0	137	113	0	35	33	34
2025	10	23	20	32	15	25.2	-2.6	1.066	0.4	0.3	0	44.3	34.4	0	137	113	0	34	33	33
2025	10	23	20	42	15	26.2	-3.4	1.066	0.5	0.4	0	44.3	34.8	0	137	113	0	34	32	34
2025	10	23	20	52	15	27.4	-3	1.066	0.4	0.3	0	43.9	34.4	0	137	113	0	35	33	34
2025	10	23	21	2	15	27.2	-4.5	1.066	0.4	0.3	0	43	34.4	0	135	113	0	35	33	34
2025	10	23	21	12	15	26.1	-3.8	1.066	0.5	0.4	0	44.3	34.8	0	137	114	0	34	33	34
2025	10	23	21	22	15	26.1	-2.1	1.066	0.4	0.3	0	43.9	34.4	0	137	113	0	35	33	34
2025	10	23	21	32	15	26.8	-2.5	1.065	0.3	0.2	0	44.3	35.3	0	137	114	0	34	32	34
2025	10	23	21	42	15	25.3	-4.6	1.065	0.5	0.4	0	44.3	34.8	0	138	114	0	35	33	34
2025	10	23	21	52	15	25.8	-2.5	1.064	0.4	0.3	0	44.3	34.8	0	138	114	0	35	33	34
2025	10	23	22	2	15	25.8	-2.1	1.065	0.3	0.2	0	44.7	34.8	0	138	114	0	34	33	34
2025	10	23	22	12	15	26.3	-2	1.065	0.4	0.3	0	44.7	35.3	0	138	115	0	34	33	35
2025	10	23	22	22	15	25.1	-3.3	1.065	0.4	0.3	0	44.3	34.8	0	137	114	0	34	33	34
2025	10	23	22	32	15	26.9	-4.1	1.065	0.4	0.3	0	43.9	34.4	0	136	113	0	34	33	34
2025	10	23	22	42	15	27.7	-3.3	1.064	0.5	0.4	0	43.9	34.8	0	137	114	0	35	33	34
2025	10	23	22	52	15	25.6	-1.7	1.065	0.5	0.4	0	44.3	34.4	0	137	113	0	34	33	34
2025	10	23	23	2	15	25.8	-2.6	1.065	0.3	0.2	0	44.7	35.3	0	138	115	0	34	33	34
2025	10	23	23	12	15	26	-3.5	1.064	0.4	0.3	0	44.3	34.8	0	137	114	0	34	33	34
2025	10	23	23	22	15	26.7	-3.5	1.064	0.3	0.2	0	44.3	34.4	0	137	113	0	34	33	34
2025	10	23	23	32	15	26.1	-2.6	1.064	0.4	0.3	0	44.3	34	0	137	113	0	34	34	33
2025	10	23	23	42	15	25.7	-2.2	1.063	0.4	0.3	0	44.3	34	0	137	113	0	34	34	34
2025	10	23	23	52	15	25.9	-2.9	1.063	0.4	0.3	0	44.3	34.4	0	138	114	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	24	0	2	15	26.3	-3.8	1.062	0.3	0.2	0	43.9	34.4	0	136	113	0	34	33	34
2025	10	24	0	12	15	26.3	-2.3	1.063	0.4	0.3	0	44.3	34.4	0	137	113	0	34	33	34
2025	10	24	0	22	15	26.7	-3.3	1.063	0.4	0.3	0	43.9	34.4	0	136	114	0	34	34	34
2025	10	24	0	32	15	26.5	-2.9	1.062	0.5	0.4	0	43.9	34.8	0	136	114	0	34	33	33
2025	10	24	0	42	15	26.4	-3.1	1.062	0.5	0.4	0	44.3	34.4	0	137	113	0	34	33	34
2025	10	24	0	52	15	26.1	-2.6	1.062	0.4	0.3	0	43.9	34.8	0	136	114	0	34	33	34
2025	10	24	1	2	15	26.4	-3	1.062	0.3	0.2	0	43.9	34.8	0	136	114	0	34	33	34
2025	10	24	1	12	15	27.2	-2.2	1.061	0.5	0.4	0	43.9	34.4	0	136	113	0	34	33	34
2025	10	24	1	22	15	25	-2.2	1.061	0.4	0.3	0	43.9	34.4	0	137	114	0	35	34	34
2025	10	24	1	32	15	26.4	-3	1.062	0.4	0.3	0	44.3	35.3	0	137	114	0	34	32	34
2025	10	24	1	42	15	25.5	-2.2	1.061	0.4	0.3	0	43.9	34.4	0	137	114	0	35	34	34
2025	10	24	1	52	15	27.2	-2.9	1.061	0.5	0.4	0	43.9	34.8	0	136	114	0	34	33	34
2025	10	24	2	2	15	26.6	-2.3	1.061	0.4	0.3	0	43.4	34.4	0	136	114	0	35	34	34
2025	10	24	2	12	15	26.5	-3.2	1.061	0.4	0.3	0	43.4	34.4	0	136	114	0	35	34	35
2025	10	24	2	22	15	25.5	-3.3	1.061	0.4	0.3	0	43.9	34	0	136	113	0	34	34	34
2025	10	24	2	32	15	27.5	-3.4	1.061	0.4	0.3	0	43.4	34.8	0	136	113	0	35	32	34
2025	10	24	2	42	15	25.7	-2.1	1.061	0.3	0.2	0	44.3	34.4	0	137	114	0	34	34	34
2025	10	24	2	52	15	27.3	-3.2	1.06	0.5	0.4	0	43.9	34.4	0	136	113	0	34	33	34
2025	10	24	3	2	15	26.4	-2.9	1.06	0.4	0.3	0	43.9	34.4	0	136	113	0	34	33	33
2025	10	24	3	12	15	25.5	-2.9	1.06	0.3	0.2	0	43.4	34.8	0	136	114	0	35	33	34
2025	10	24	3	22	15	26.3	-3	1.06	0.5	0.5	0	43.4	34.8	0	136	114	0	35	33	34
2025	10	24	3	32	15	26.2	-2.7	1.06	0.3	0.2	0	43	34.4	0	135	113	0	35	33	34
2025	10	24	3	42	15	25.9	-2.4	1.06	0.4	0.3	0	43.4	34	0	135	113	0	34	34	34
2025	10	24	3	52	15	26.3	-2.8	1.06	0.4	0.3	0	43.4	34.4	0	136	113	0	35	33	34
2025	10	24	4	2	15	25.9	-2.1	1.06	0.5	0.4	0	43.4	34.8	0	135	113	0	34	32	34
2025	10	24	4	12	15	26.2	-2.4	1.06	0.5	0.4	0	44.7	34.4	0	138	113	0	34	33	34
2025	10	24	4	22	15	26.9	-3.3	1.06	0.5	0.4	0	44.7	34.4	0	138	113	0	34	33	34
2025	10	24	4	32	15	26.2	-2.2	1.06	0.3	0.2	0	44.7	34.4	0	138	113	0	34	33	34
2025	10	24	4	42	15	25.9	-3.2	1.06	0.5	0.4	0	43.9	34.8	0	137	114	0	35	33	34
2025	10	24	4	52	15	26.6	-3.4	1.06	0.5	0.4	0	45.2	35.3	0	140	115	0	35	33	34
2025	10	24	5	2	15	24.9	-2.2	1.06	0.5	0.4	0	44.7	34.4	0	138	114	0	34	34	34
2025	10	24	5	12	15	26.3	-2.1	1.06	0.5	0.4	0	44.3	34.4	0	137	113	0	34	33	34
2025	10	24	5	22	15	25.5	-3.1	1.06	0.4	0.3	0	44.3	34.4	0	137	113	0	34	33	34
2025	10	24	5	32	15	26.4	-2.4	1.06	0.3	0.2	0	44.3	34.4	0	137	113	0	34	33	34
2025	10	24	5	42	15	26.4	-2.6	1.06	0.5	0.4	0	43.9	33.5	0	136	112	0	34	34	34
2025	10	24	5	52	15	26.3	-2.8	1.06	0.3	0.2	0	44.3	34.4	0	137	113	0	34	33	34
2025	10	24	6	2	15	25.6	-1.7	1.06	0.5	0.4	0	44.7	34.4	0	138	113	0	34	33	35
2025	10	24	6	12	15	26.4	-2.4	1.06	0.6	0.5	0	43.9	34.4	0	137	113	0	35	33	34
2025	10	24	6	22	15	25.8	-3.6	1.06	0.5	0.4	0	43.9	34	0	137	112	0	35	33	34
2025	10	24	6	32	15	25.9	-2.2	1.06	0.4	0.3	0	43.4	34	0	136	112	0	35	33	34
2025	10	24	6	42	15	26.3	-2.8	1.06	0.3	0.2	0	43.4	33.5	0	136	112	0	35	34	34
2025	10	24	6	52	15	26.7	-3.4	1.06	0.3	0.2	0	43.9	34	0	136	112	0	34	33	34
2025	10	24	7	2	15	26.1	-3	1.06	0.4	0.3	0	43.4	34	0	136	112	0	35	33	34
2025	10	24	7	12	15	27.1	-1.8	1.06	0.4	0.3	0	43	33.5	0	135	111	0	35	33	34
2025	10	24	7	22	15	26.2	-4.2	1.06	0.3	0.2	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	24	7	32	15	26.1	-2.8	1.06	0.4	0.3	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	24	7	42	15	27.1	-3.1	1.06	0.4	0.3	0	42.6	32.3	0	133	109	0	34	34	34
2025	10	24	7	52	15	25.4	-2.9	1.06	0.4	0.3	0	43	33.1	0	134	110	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	24	8	2	15	26.7	-2.2	1.06	0.4	0.3	0	43	33.5	0	134	110	0	34	32	34
2025	10	24	8	12	15	26.5	-3	1.06	0.3	0.2	0	42.6	32.3	0	133	109	0	34	34	34
2025	10	24	8	22	15	26	-3	1.06	0.4	0.3	0	42.1	32.7	0	133	109	0	35	33	34
2025	10	24	8	32	15	25.5	-2.7	1.06	0.4	0.3	0	41.7	32.7	0	132	109	0	35	33	33
2025	10	24	8	42	15	26.1	-3.9	1.06	0.4	0.3	0	41.7	32.7	0	132	109	0	35	33	34
2025	10	24	8	52	15	25.6	-2.8	1.06	0.5	0.4	0	41.7	32.7	0	132	109	0	35	33	35
2025	10	24	9	2	15	26.2	-2.4	1.06	0.4	0.3	0	42.1	33.1	0	133	110	0	35	33	34
2025	10	24	9	12	15	25	-1.5	1.06	0.5	0.5	0	42.1	32.3	0	132	109	0	34	34	34
2025	10	24	9	22	15	25.6	-2.2	1.06	0.4	0.3	0	41.7	31.8	0	131	107	0	34	33	34
2025	10	24	9	32	15	26	-2.4	1.06	0.5	0.5	0	41.3	31.8	0	130	107	0	34	33	33
2025	10	24	9	42	15	26	-2.9	1.06	0.3	0.2	0	41.7	32.3	0	131	108	0	34	33	35
2025	10	24	9	52	15	26.2	-2.7	1.06	0.3	0.2	0	41.3	31.4	0	130	107	0	34	34	34
2025	10	24	10	2	15	25.7	-2.7	1.06	0.5	0.4	0	40.9	31.4	0	129	106	0	34	33	34
2025	10	24	10	12	15	26.6	-3	1.06	0.4	0.3	0	41.3	32.3	0	131	108	0	35	33	34
2025	10	24	10	22	15	25.4	-2.1	1.06	0.3	0.2	0	41.3	31.8	0	130	107	0	34	33	33
2025	10	24	10	32	15	26.5	-2.9	1.06	0.4	0.3	0	41.3	32.3	0	130	108	0	34	33	35
2025	10	24	10	42	15	25.2	-2.6	1.06	0.4	0.3	0	41.3	31.8	0	130	107	0	34	33	34
2025	10	24	10	52	15	26.5	-3.3	1.06	0.4	0.3	0	41.3	32.7	0	130	108	0	34	32	34
2025	10	24	11	2	15	26	-2.4	1.06	0.4	0.3	0	40.9	31	0	129	106	0	34	34	34
2025	10	24	11	12	15	26.9	-3.2	1.06	0.4	0.3	0	40	31.4	0	128	106	0	35	33	34
2025	10	24	11	22	15	25.8	-3.1	1.06	0.3	0.2	0	40.9	31.8	0	129	107	0	34	33	34
2025	10	24	11	32	15	25.2	-2.7	1.06	0.4	0.3	0	40.4	31.8	0	129	107	0	35	33	34
2025	10	24	11	42	15	26.9	-2.2	1.06	0.5	0.4	0	41.3	31.8	0	130	107	0	34	33	34
2025	10	24	11	52	15	26.1	-2.9	1.059	0.4	0.3	0	40.9	31.4	0	130	107	0	35	34	33
2025	10	24	12	2	15	25.9	-2.7	1.06	0.4	0.3	0	40.9	31.4	0	129	106	0	34	33	34
2025	10	24	12	12	15	25.3	-2.3	1.06	0.4	0.3	0	41.3	31.4	0	130	107	0	34	34	34
2025	10	24	12	22	15	25.3	-3	1.059	0.4	0.3	0	40.4	31	0	129	106	0	35	34	34
2025	10	24	12	32	15	25.3	-2.2	1.06	0.4	0.3	0	40.9	31.8	0	130	107	0	35	33	34
2025	10	24	12	42	15	26.4	-2.7	1.059	0.4	0.3	0	40.9	31.4	0	129	106	0	34	33	34
2025	10	24	12	52	15	25.8	-3	1.059	0.5	0.4	0	40.4	31.8	0	129	107	0	35	33	34
2025	10	24	13	2	15	27	-2.3	1.059	0.4	0.3	0	40.9	31.8	0	129	107	0	34	33	34
2025	10	24	13	12	15	25.8	-2.6	1.059	0.4	0.3	0	40	31.4	0	128	106	0	35	33	34
2025	10	24	13	22	15	25.3	-1.9	1.059	0.3	0.2	0	40	31	0	127	105	0	34	33	33
2025	10	24	13	32	15	25.7	-2.2	1.059	0.4	0.3	0	40	31	0	128	106	0	35	34	34
2025	10	24	13	42	15	26.3	-1.7	1.059	0.4	0.3	0	40.4	31.4	0	128	106	0	34	33	34
2025	10	24	13	52	15	25.2	-2.3	1.059	0.4	0.3	0	40.4	31.8	0	129	107	0	35	33	34
2025	10	24	14	2	15	25.6	-2.7	1.059	0.4	0.3	0	40.9	31.8	0	129	107	0	34	33	34
2025	10	24	14	12	15	25.3	-2.7	1.059	0.4	0.3	0	40.9	31.8	0	129	107	0	34	33	34
2025	10	24	14	22	15	25	-3.3	1.058	0.3	0.2	0	40.9	31.8	0	129	107	0	34	33	34
2025	10	24	14	32	15	24.3	-2.7	1.059	0.3	0.2	0	40.4	31.8	0	129	107	0	35	33	34
2025	10	24	14	42	15	24.9	-2.6	1.058	0.5	0.4	0	40.9	32.3	0	130	108	0	35	33	34
2025	10	24	14	52	15	24.8	-1.9	1.058	0.3	0.2	0	41.3	31.8	0	130	108	0	34	34	34
2025	10	24	15	2	15	25.3	-2.2	1.058	0.4	0.3	0	40.9	32.7	0	130	109	0	35	33	34
2025	10	24	15	12	15	25.2	-3.1	1.058	0.3	0.2	0	41.7	32.7	0	131	109	0	34	33	33
2025	10	24	15	22	15	24.6	-3.4	1.058	0.4	0.3	0	41.3	33.1	0	131	110	0	35	33	34
2025	10	24	15	32	15	25.5	-1.5	1.057	0.4	0.3	0	42.1	33.1	0	132	110	0	34	33	34
2025	10	24	15	42	15	25.7	-3.3	1.057	0.4	0.3	0	41.3	32.3	0	130	108	0	34	33	33
2025	10	24	15	52	15	25.4	-1.7	1.057	0.4	0.3	0	41.7	32.7	0	131	109	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	24	16	2	15	25.2	-3.1	1.057	0.3	0.2	0	41.7	33.1	0	131	109	0	34	32	34
2025	10	24	16	12	15	23.8	-3.1	1.057	0.3	0.2	0	41.3	32.3	0	130	108	0	34	33	34
2025	10	24	16	22	15	25.7	-3.7	1.057	0.5	0.4	0	41.3	32.7	0	130	109	0	34	33	34
2025	10	24	16	32	15	25	-3.3	1.057	0.5	0.4	0	40.9	31.8	0	129	107	0	34	33	34
2025	10	24	16	42	15	24.8	-3.1	1.057	0.3	0.2	0	40.9	31.4	0	129	106	0	34	33	34
2025	10	24	16	52	15	23.7	-3.1	1.057	0.4	0.3	0	40.9	31.4	0	129	106	0	34	33	34
2025	10	24	17	2	15	26.7	-3.4	1.057	0.4	0.3	0	40.4	31.8	0	129	107	0	35	33	34
2025	10	24	17	12	15	25.2	-3	1.057	0.4	0.3	0	41.3	31.8	0	130	107	0	34	33	34
2025	10	24	17	22	15	25.6	-2.4	1.057	0.4	0.3	0	40.4	31.4	0	129	106	0	35	33	34
2025	10	24	17	32	15	25.1	-2.4	1.057	0.5	0.4	0	40.9	31.4	0	129	106	0	34	33	34
2025	10	24	17	42	15	25.7	-3.2	1.057	0.5	0.4	0	41.3	31.8	0	130	107	0	34	33	34
2025	10	24	17	52	15	25.5	-1.7	1.057	0.5	0.4	0	41.3	32.7	0	130	108	0	34	32	34
2025	10	24	18	2	15	26.6	-2.5	1.057	0.4	0.3	0	42.1	32.3	0	131	108	0	33	33	34
2025	10	24	18	12	15	26.5	-3.5	1.057	0.4	0.3	0	42.1	32.3	0	132	109	0	34	34	33
2025	10	24	18	22	15	26.1	-3.4	1.057	0.5	0.4	0	41.7	32.3	0	131	108	0	34	33	34
2025	10	24	18	32	15	26.1	-3.7	1.057	0.3	0.2	0	42.1	32.3	0	132	108	0	34	33	34
2025	10	24	18	42	15	25.7	-3.5	1.056	0.4	0.3	0	41.7	33.1	0	132	109	0	35	32	35
2025	10	24	18	52	15	26.3	-2.6	1.056	0.3	0.2	0	42.6	33.1	0	133	110	0	34	33	34
2025	10	24	19	2	15	25.7	-3	1.056	0.3	0.2	0	43	33.5	0	134	111	0	34	33	34
2025	10	24	19	12	15	25.6	-3.1	1.056	0.4	0.3	0	43	33.5	0	134	111	0	34	33	33
2025	10	24	19	22	15	25.6	-4.3	1.056	0.4	0.3	0	43.4	34	0	135	112	0	34	33	34
2025	10	24	19	32	15	26.7	-3.9	1.056	0.4	0.3	0	42.6	34	0	134	111	0	35	32	34
2025	10	24	19	42	15	25.1	-3.4	1.056	0.4	0.3	0	43.4	33.5	0	135	112	0	34	34	34
2025	10	24	19	52	15	25.8	-3.3	1.056	0.4	0.3	0	43.4	34	0	135	112	0	34	33	34
2025	10	24	20	2	15	24.3	-2.8	1.056	0.3	0.2	0	43.4	34	0	135	112	0	34	33	33
2025	10	24	20	12	15	25.7	-3.4	1.056	0.5	0.5	0	42.6	34	0	134	112	0	35	33	34
2025	10	24	20	22	15	25.6	-1.7	1.056	0.3	0.2	0	43.4	34	0	135	112	0	34	33	34
2025	10	24	20	32	15	26.8	-2.6	1.056	0.3	0.2	0	43.4	34.4	0	135	112	0	34	32	33
2025	10	24	20	42	15	25.1	-2.8	1.056	0.3	0.2	0	43	32.3	0	135	107	0	35	32	34
2025	10	24	20	52	15	26.4	-3	1.056	0.3	0.2	0	43.4	34	0	135	112	0	34	33	34
2025	10	24	21	2	15	25.1	-3	1.055	0.4	0.3	0	43.4	34	0	135	112	0	34	33	34
2025	10	24	21	12	15	25.9	-2.8	1.055	0.4	0.3	0	43.9	34	0	136	113	0	34	34	34
2025	10	24	21	22	15	25.3	-3.9	1.055	0.3	0.2	0	43.4	34	0	135	112	0	34	33	34
2025	10	24	21	32	15	26.4	-1.9	1.055	0.4	0.3	0	43	34	0	135	112	0	35	33	34
2025	10	24	21	42	15	26.7	-2.1	1.055	0.5	0.4	0	43.4	34.4	0	135	113	0	34	33	33
2025	10	24	21	52	15	26.4	-1.7	1.055	0.4	0.3	0	43	34	0	135	112	0	35	33	34
2025	10	24	22	2	15	26.1	-2.1	1.055	0.4	0.3	0	43	34.4	0	135	113	0	35	33	34
2025	10	24	22	12	15	25.6	-3	1.056	0.5	0.4	0	43.9	34.4	0	136	113	0	34	33	34
2025	10	24	22	22	15	25.9	-3.3	1.056	0.5	0.4	0	43.9	34	0	136	112	0	34	33	34
2025	10	24	22	32	15	25.8	-2.7	1.056	0.4	0.3	0	43.9	34	0	136	112	0	34	33	33
2025	10	24	22	42	15	26.3	-3.2	1.057	0.4	0.3	0	44.3	34.4	0	137	113	0	34	33	34
2025	10	24	22	52	15	25.9	-2	1.056	0.3	0.2	0	43.9	34.8	0	137	113	0	35	32	34
2025	10	24	23	2	15	26.8	-2.9	1.056	0.4	0.3	0	43.9	34	0	136	112	0	34	33	34
2025	10	24	23	12	15	26.2	-2.4	1.057	0.5	0.5	0	43.9	34	0	136	112	0	34	33	35
2025	10	24	23	22	15	26.3	-2.6	1.057	0.4	0.3	0	44.3	34.4	0	137	113	0	34	33	34
2025	10	24	23	32	15	26.1	-2.8	1.057	0.4	0.3	0	43.9	34.4	0	137	113	0	35	33	34
2025	10	24	23	42	15	26.3	-2.3	1.056	0.5	0.4	0	44.3	34.4	0	137	113	0	34	33	34
2025	10	24	23	52	15	26	-2.7	1.056	0.3	0.2	0	43.9	34	0	136	112	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	25	0	2	15	26	-2.4	1.056	0.5	0.4	0	43.9	34	0	136	112	0	34	33	34
2025	10	25	0	12	15	25.9	-3.4	1.056	0.5	0.4	0	43.4	33.5	0	136	112	0	35	34	34
2025	10	25	0	22	15	26.3	-3	1.056	0.4	0.3	0	43	33.5	0	135	112	0	35	34	34
2025	10	25	0	32	15	25.2	-3.2	1.056	0.4	0.3	0	43.4	33.5	0	136	111	0	35	33	34
2025	10	25	0	42	15	26.4	-2.8	1.056	0.5	0.5	0	43.9	33.5	0	136	112	0	34	34	34
2025	10	25	0	52	15	26.2	-4	1.056	0.3	0.2	0	43	33.1	0	135	111	0	35	34	34
2025	10	25	1	2	15	25.4	-2.4	1.056	0.3	0.2	0	43	33.5	0	135	111	0	35	33	34
2025	10	25	1	12	15	24.4	-1.9	1.056	0.3	0.2	0	43.9	33.5	0	136	112	0	34	34	34
2025	10	25	1	22	15	25.9	-2.6	1.056	0.4	0.3	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	25	1	32	15	26	-2.9	1.056	0.4	0.3	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	25	1	42	15	25.1	-2.8	1.056	0.5	0.4	0	43.4	33.5	0	136	112	0	35	34	34
2025	10	25	1	52	15	27	-1.4	1.055	0.5	0.4	0	43.4	34	0	135	112	0	34	33	34
2025	10	25	2	2	15	26.7	-2.1	1.055	0.3	0.2	0	43	34	0	135	112	0	35	33	34
2025	10	25	2	12	15	26.1	-3.8	1.055	0.4	0.3	0	43.9	34	0	136	112	0	34	33	34
2025	10	25	2	22	15	26	-2.7	1.055	0.5	0.4	0	43.9	33.5	0	136	112	0	34	34	34
2025	10	25	2	32	15	26	-3	1.055	0.4	0.3	0	43.9	34	0	136	112	0	34	33	34
2025	10	25	2	42	15	25.3	-2.1	1.055	0.4	0.3	0	43.9	34	0	136	112	0	34	33	34
2025	10	25	2	52	15	26.6	-3.8	1.055	0.4	0.3	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	25	3	2	15	25.7	-2.9	1.055	0.4	0.3	0	43.9	33.5	0	136	112	0	34	34	34
2025	10	25	3	12	15	26.1	-2.5	1.055	0.3	0.2	0	43.4	34	0	135	112	0	34	33	34
2025	10	25	3	22	15	27.5	-2.1	1.055	0.5	0.4	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	25	3	32	15	24.5	-1.6	1.055	0.4	0.3	0	43.9	34	0	136	112	0	34	33	34
2025	10	25	3	42	15	26.7	-2.2	1.055	0.3	0.2	0	43.4	33.1	0	135	111	0	34	34	35
2025	10	25	3	52	15	25.1	-1.5	1.055	0.5	0.4	0	43.4	33.1	0	135	111	0	34	34	34
2025	10	25	4	2	15	26.4	-2.1	1.055	0.5	0.4	0	43.4	34	0	135	112	0	34	33	34
2025	10	25	4	12	15	25.8	-2.6	1.055	0.5	0.4	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	25	4	22	15	25.2	-2.7	1.055	0.4	0.3	0	43.4	33.5	0	135	112	0	34	34	33
2025	10	25	4	32	15	25.9	-4.3	1.055	0.4	0.3	0	43.4	33.1	0	135	111	0	34	34	33
2025	10	25	4	42	15	26	-3.5	1.055	0.3	0.2	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	25	4	52	15	25.9	-2.8	1.055	0.4	0.3	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	25	5	2	15	25.8	-2.6	1.055	0.4	0.3	0	43	34	0	135	112	0	35	33	34
2025	10	25	5	12	15	26.3	-3.4	1.055	0.3	0.2	0	43.4	33.1	0	135	111	0	34	34	34
2025	10	25	5	22	15	26	-3.5	1.055	0.5	0.4	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	25	5	32	15	25.9	-2.5	1.055	0.4	0.3	0	43	34.4	0	135	112	0	35	32	34
2025	10	25	5	42	15	25.6	-2.6	1.055	0.4	0.3	0	43.4	34	0	135	112	0	34	33	34
2025	10	25	5	52	15	24.9	-2.3	1.055	0.3	0.2	0	43.4	34	0	135	112	0	34	33	34
2025	10	25	6	2	15	26.6	-3.8	1.055	0.5	0.4	0	43.4	34	0	135	112	0	34	33	34
2025	10	25	6	12	15	25.1	-2.3	1.055	0.5	0.4	0	43	34	0	135	112	0	35	33	34
2025	10	25	6	22	15	25.4	-3	1.055	0.4	0.3	0	42.6	34	0	134	111	0	35	32	34
2025	10	25	6	32	15	25.4	-2.9	1.055	0.4	0.3	0	43	33.1	0	134	111	0	34	34	34
2025	10	25	6	42	15	25.8	-3.3	1.055	0.5	0.4	0	43	32.7	0	134	110	0	34	34	34
2025	10	25	6	52	15	25.7	-2.2	1.055	0.5	0.5	0	42.1	33.1	0	133	110	0	35	33	34
2025	10	25	7	2	15	25.3	-2.5	1.055	0.4	0.3	0	42.6	33.1	0	133	110	0	34	33	34
2025	10	25	7	12	15	25.9	-2.5	1.055	0.4	0.3	0	42.6	32.7	0	133	110	0	34	34	34
2025	10	25	7	22	15	27.5	-2.6	1.055	0.3	0.2	0	42.1	32.7	0	132	109	0	34	33	34
2025	10	25	7	32	15	26.1	-3.3	1.055	0.4	0.3	0	41.3	32.7	0	131	109	0	35	33	33
2025	10	25	7	42	15	26.3	-2.2	1.055	0.4	0.3	0	41.3	32.3	0	130	108	0	34	33	35
2025	10	25	7	52	15	26.6	-3.8	1.055	0.5	0.4	0	41.3	32.3	0	130	108	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	25	8	2	15	25.9	-3	1.055	0.3	0.2	0	40.9	31.4	0	130	106	0	35	33	34
2025	10	25	8	12	15	26.6	-3.6	1.055	0.3	0.2	0	40.4	31.4	0	129	106	0	35	33	34
2025	10	25	8	22	15	26.1	-4.1	1.055	0.4	0.3	0	40	31.4	0	128	106	0	35	33	33
2025	10	25	8	32	15	25.1	-2.8	1.055	0.3	0.2	0	40	31	0	128	105	0	35	33	34
2025	10	25	8	42	15	26.9	-3.3	1.055	0.4	0.3	0	39.6	30.5	0	126	104	0	34	33	34
2025	10	25	8	52	15	25.2	-3.5	1.055	0.3	0.2	0	40	30.5	0	127	104	0	34	33	34
2025	10	25	9	2	15	26.3	-2.7	1.055	0.4	0.3	0	40	31	0	127	105	0	34	33	34
2025	10	25	9	12	15	26	-2.7	1.055	0.4	0.3	0	40	31	0	127	105	0	34	33	34
2025	10	25	9	22	15	25.3	-2.8	1.055	0.5	0.4	0	40	31	0	127	105	0	34	33	34
2025	10	25	9	32	15	25.8	-3.6	1.055	0.4	0.3	0	39.6	30.5	0	127	105	0	35	34	34
2025	10	25	9	42	15	25.7	-2.5	1.055	0.5	0.4	0	39.6	30.1	0	126	104	0	34	34	34
2025	10	25	9	52	15	25.5	-3.4	1.055	0.4	0.3	0	39.1	30.1	0	126	103	0	35	33	34
2025	10	25	10	2	15	26.5	-1.9	1.055	0.5	0.4	0	39.6	30.5	0	127	104	0	35	33	34
2025	10	25	10	12	15	25.9	-2.5	1.055	0.4	0.3	0	40	31	0	127	105	0	34	33	34
2025	10	25	10	22	15	27.5	-3.6	1.055	0.4	0.3	0	40.4	31	0	128	105	0	34	33	34
2025	10	25	10	32	15	25.8	-2.3	1.055	0.4	0.3	0	40	31	0	128	105	0	35	33	34
2025	10	25	10	42	15	25	-2.1	1.055	0.3	0.2	0	40.4	31.4	0	129	107	0	35	34	33
2025	10	25	10	52	15	26.4	-3.3	1.055	0.4	0.3	0	41.3	31.8	0	130	107	0	34	33	34
2025	10	25	11	2	15	25.7	-2.4	1.056	0.4	0.3	0	40	31	0	128	106	0	35	34	34
2025	10	25	11	12	15	25.8	-2.8	1.055	0.3	0.2	0	40	31	0	127	105	0	34	33	34
2025	10	25	11	22	15	26.8	-2.9	1.056	0.5	0.4	0	39.6	31	0	127	105	0	35	33	35
2025	10	25	11	32	15	26.5	-3.4	1.056	0.4	0.3	0	39.6	31	0	127	105	0	35	33	33
2025	10	25	11	42	15	25.7	-3	1.056	0.5	0.4	0	40	31	0	127	105	0	34	33	34
2025	10	25	11	52	15	26	-3.2	1.056	0.5	0.4	0	40	31.4	0	127	105	0	34	32	34
2025	10	25	12	2	15	25.3	-2.5	1.056	0.5	0.4	0	40	31.4	0	128	106	0	35	33	34
2025	10	25	12	12	15	26.3	-3	1.056	0.4	0.3	0	40	31.4	0	127	106	0	34	33	35
2025	10	25	12	22	15	25.2	-3.4	1.056	0.4	0.3	0	39.6	31	0	127	105	0	35	33	34
2025	10	25	12	32	15	27.1	-2.8	1.056	0.5	0.5	0	40.9	32.3	0	130	108	0	35	33	34
2025	10	25	12	42	15	25.6	-3.2	1.056	0.3	0.2	0	41.3	32.7	0	130	109	0	34	33	34
2025	10	25	12	52	15	25.7	-2.6	1.056	0.3	0.2	0	40.9	31.8	0	129	107	0	34	33	33
2025	10	25	13	2	15	25.8	-2.3	1.055	0.3	0.2	0	41.3	32.7	0	130	109	0	34	33	34
2025	10	25	13	12	15	25.7	-2.6	1.055	0.5	0.4	0	41.3	32.7	0	130	109	0	34	33	35
2025	10	25	13	22	15	26.1	-3.4	1.054	0.3	0.2	0	40.9	31.8	0	129	107	0	34	33	34
2025	10	25	13	32	15	25.5	-2.6	1.054	0.4	0.3	0	40.4	31.8	0	128	107	0	34	33	34
2025	10	25	13	42	15	26.1	-3.8	1.055	0.5	0.4	0	39.1	31	0	126	105	0	35	33	34
2025	10	25	13	52	15	25.7	-3	1.054	0.4	0.3	0	39.1	31	0	126	105	0	35	33	35
2025	10	25	14	2	15	24.8	-3.5	1.054	0.4	0.3	0	40	31.4	0	127	106	0	34	33	34
2025	10	25	14	12	15	26.5	-2.6	1.054	0.3	0.2	0	39.6	31.8	0	127	107	0	35	33	33
2025	10	25	14	22	15	25.6	-2.7	1.053	0.5	0.4	0	40	31.4	0	127	107	0	34	34	34
2025	10	25	14	32	15	25.2	-3	1.053	0.5	0.4	0	39.1	31.4	0	126	106	0	35	33	34
2025	10	25	14	42	15	25	-3.3	1.054	0.3	0.2	0	40	31.4	0	127	106	0	34	33	34
2025	10	25	14	52	15	24.7	-2.6	1.053	0.3	0.2	0	40.9	31.8	0	129	108	0	34	34	34
2025	10	25	15	2	15	25.5	-2.3	1.053	0.4	0.3	0	40.4	31.4	0	128	106	0	34	33	34
2025	10	25	15	12	15	25.2	-3.4	1.053	0.4	0.3	0	40.4	31.4	0	128	106	0	34	33	34
2025	10	25	15	22	15	25.6	-2.3	1.054	0.5	0.4	0	40	31	0	128	106	0	35	34	34
2025	10	25	15	32	15	24.9	-2.2	1.054	0.5	0.4	0	40.4	31.8	0	128	107	0	34	33	34
2025	10	25	15	42	15	24.5	-3.3	1.053	0.4	0.3	0	40.4	31.8	0	128	107	0	34	33	33
2025	10	25	15	52	15	24.9	-3.5	1.053	0.4	0.3	0	40.4	31.8	0	128	107	0	34	33	33

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	25	16	2	15	25.2	-2.6	1.052	0.4	0.3	0	40	31.4	0	127	106	0	34	33	34
2025	10	25	16	12	15	25.3	-2.8	1.054	0.4	0.3	0	40.4	31.4	0	128	106	0	34	33	34
2025	10	25	16	22	15	25.1	-2.7	1.054	0.4	0.3	0	40	31	0	127	105	0	34	33	33
2025	10	25	16	32	15	25.9	-2.7	1.054	0.4	0.3	0	40.4	31.8	0	128	107	0	34	33	34
2025	10	25	16	42	15	25.7	-2.6	1.054	0.4	0.3	0	40.4	31.8	0	128	107	0	34	33	34
2025	10	25	16	52	15	25.2	-2.6	1.054	0.4	0.3	0	40.4	31.8	0	128	107	0	34	33	34
2025	10	25	17	2	15	24.7	-3	1.054	0.5	0.5	0	40.4	31.8	0	129	107	0	35	33	34
2025	10	25	17	12	15	25.1	-2.9	1.054	0.4	0.3	0	40.4	31.4	0	128	107	0	34	34	34
2025	10	25	17	22	15	26.4	-2.8	1.054	0.4	0.3	0	40.4	32.3	0	128	107	0	34	32	34
2025	10	25	17	32	15	25.7	-2.1	1.053	0.3	0.2	0	40.4	31.8	0	129	107	0	35	33	34
2025	10	25	17	42	15	25.2	-2.4	1.053	0.5	0.4	0	40.9	31.8	0	129	107	0	34	33	34
2025	10	25	17	52	15	25.8	-1.5	1.053	0.5	0.5	0	40.9	31.4	0	129	107	0	34	34	34
2025	10	25	18	2	15	25.7	-3	1.053	0.3	0.2	0	41.7	32.3	0	131	109	0	34	34	33
2025	10	25	18	12	15	25.5	-2.9	1.053	0.4	0.3	0	40.9	32.3	0	130	109	0	35	34	34
2025	10	25	18	22	15	25.5	-2.2	1.053	0.5	0.5	0	41.3	32.7	0	130	109	0	34	33	34
2025	10	25	18	32	15	26	-2.7	1.053	0.5	0.5	0	41.3	32.7	0	131	109	0	35	33	34
2025	10	25	18	42	15	25.9	-2.2	1.053	0.5	0.4	0	41.7	32.7	0	131	109	0	34	33	34
2025	10	25	18	52	15	26	-3.5	1.053	0.3	0.2	0	42.1	33.1	0	132	111	0	34	34	34
2025	10	25	19	2	15	26.7	-3.7	1.053	0.4	0.3	0	42.6	33.5	0	133	111	0	34	33	34
2025	10	25	19	12	15	25.7	-2.5	1.053	0.4	0.3	0	42.6	34	0	133	112	0	34	33	34
2025	10	25	19	22	15	24.1	-3	1.053	0.4	0.3	0	43	34	0	134	112	0	34	33	34
2025	10	25	19	32	15	26.2	-2.2	1.053	0.4	0.3	0	43	34	0	134	112	0	34	33	34
2025	10	25	19	42	15	26.4	-2.3	1.053	0.4	0.3	0	42.6	34	0	133	112	0	34	33	35
2025	10	25	19	52	15	25.1	-2.8	1.053	0.3	0.2	0	42.6	33.5	0	134	112	0	35	34	34
2025	10	25	20	2	15	26.2	-2.7	1.053	0.5	0.4	0	43	34	0	134	112	0	34	33	34
2025	10	25	20	12	15	25.4	-2.8	1.053	0.5	0.4	0	43	34	0	134	112	0	34	33	34
2025	10	25	20	22	15	25.7	-2.7	1.053	0.5	0.4	0	43	34	0	134	112	0	34	33	34
2025	10	25	20	32	15	26.3	-3.2	1.053	0.4	0.3	0	42.6	34	0	134	112	0	35	33	33
2025	10	25	20	42	15	26.1	-3.4	1.053	0.4	0.3	0	43	34	0	134	112	0	34	33	35
2025	10	25	20	52	15	24.6	-3.4	1.053	0.4	0.3	0	44.3	34	0	137	112	0	34	33	34
2025	10	25	21	2	15	27.5	-2.2	1.053	0.5	0.4	0	43.9	34	0	136	112	0	34	33	34
2025	10	25	21	12	15	24.9	-2.4	1.052	0.5	0.4	0	44.7	34.4	0	138	113	0	34	33	35
2025	10	25	21	22	15	25	-3.4	1.052	0.4	0.3	0	43.9	34	0	136	112	0	34	33	35
2025	10	25	21	32	15	25	-2.6	1.052	0.5	0.4	0	43.9	34	0	137	113	0	35	34	34
2025	10	25	21	42	15	26	-3.7	1.052	0.4	0.3	0	43.9	34	0	137	112	0	35	33	34
2025	10	25	21	52	15	26.1	-3.6	1.052	0.4	0.3	0	43.9	33.5	0	136	112	0	34	34	34
2025	10	25	22	2	15	25.3	-2.8	1.052	0.4	0.3	0	43.9	34.4	0	137	113	0	35	33	34
2025	10	25	22	12	15	24	-2.3	1.052	0.5	0.4	0	43.9	34.4	0	137	113	0	35	33	34
2025	10	25	22	22	15	25.7	-3.4	1.052	0.5	0.4	0	43.9	34	0	136	112	0	34	33	34
2025	10	25	22	32	15	26.4	-2.6	1.052	0.5	0.5	0	43.4	33.5	0	135	112	0	34	34	34
2025	10	25	22	42	15	25.9	-2.8	1.052	0.5	0.4	0	44.3	33.5	0	137	112	0	34	34	34
2025	10	25	22	52	15	25.9	-2.6	1.052	0.5	0.4	0	43.4	34	0	136	112	0	35	33	34
2025	10	25	23	2	15	24.4	-3.1	1.052	0.4	0.3	0	43.9	34	0	136	112	0	34	33	35
2025	10	25	23	12	15	26	-2.7	1.052	0.5	0.4	0	45.6	36.1	0	141	116	0	35	32	34
2025	10	25	23	22	15	27.1	-3.5	1.052	0.5	0.4	0	43.9	34	0	137	112	0	35	33	34
2025	10	25	23	32	15	25.8	-2.9	1.052	0.5	0.4	0	43.9	34	0	136	112	0	34	33	34
2025	10	25	23	42	15	26.8	-2.4	1.052	0.3	0.2	0	43.4	33.5	0	135	112	0	34	34	34
2025	10	25	23	52	15	26	-2.9	1.052	0.5	0.4	0	44.3	33.5	0	137	112	0	34	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	26	0	2	15	26.1	-3.9	1.052	0.5	0.4	0	43.9	34	0	137	112	0	35	33	34
2025	10	26	0	12	15	24.9	-2.3	1.052	0.5	0.5	0	43.9	33.5	0	136	112	0	34	34	33
2025	10	26	0	22	15	24.8	-2.9	1.052	0.4	0.3	0	44.3	34	0	137	112	0	34	33	34
2025	10	26	0	32	15	25.7	-2.3	1.052	0.4	0.3	0	43.4	34	0	136	112	0	35	33	33
2025	10	26	0	42	15	25.7	-2.8	1.052	0.4	0.3	0	43.4	33.5	0	136	112	0	35	34	34
2025	10	26	0	52	15	26.5	-3.7	1.052	0.5	0.4	0	43.9	33.5	0	136	111	0	34	33	34
2025	10	26	1	2	15	25.4	-3	1.052	0.4	0.3	0	43.9	34	0	136	112	0	34	33	35
2025	10	26	1	12	15	24.6	-2.5	1.051	0.4	0.3	0	43.4	33.5	0	136	111	0	35	33	34
2025	10	26	1	22	15	25	-2.6	1.052	0.4	0.3	0	43.9	33.5	0	137	112	0	35	34	33
2025	10	26	1	32	15	26.1	-2.5	1.052	0.4	0.3	0	44.3	34	0	137	113	0	34	34	34
2025	10	26	1	42	15	24.7	-3.6	1.051	0.4	0.3	0	43.9	33.5	0	136	112	0	34	34	34
2025	10	26	1	52	15	25.9	-2.5	1.051	0.5	0.4	0	43.9	33.5	0	136	112	0	34	34	33
2025	10	26	2	2	15	24.9	-2.2	1.051	0.4	0.3	0	43.9	33.5	0	136	112	0	34	34	34
2025	10	26	2	12	15	24	-2.7	1.051	0.4	0.3	0	43.4	34	0	136	112	0	35	33	34
2025	10	26	2	22	15	25.7	-3	1.051	0.5	0.4	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	26	2	32	15	26.5	-2.4	1.051	0.5	0.5	0	43	33.5	0	135	111	0	35	33	34
2025	10	26	2	42	15	25.9	-2.1	1.051	0.4	0.3	0	43	33.1	0	135	111	0	35	34	34
2025	10	26	2	52	15	24.5	-2.2	1.051	0.5	0.4	0	43.4	34	0	136	112	0	35	33	34
2025	10	26	3	2	15	24.7	-1.9	1.051	0.3	0.2	0	43.4	34	0	136	112	0	35	33	34
2025	10	26	3	12	15	24.9	-3	1.051	0.4	0.3	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	26	3	22	15	25.9	-2.8	1.051	0.3	0.2	0	43.4	33.1	0	135	111	0	34	34	34
2025	10	26	3	32	15	25.5	-3	1.051	0.4	0.3	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	26	3	42	15	25.7	-3.3	1.051	0.5	0.4	0	43.4	33.1	0	135	110	0	34	33	34
2025	10	26	3	52	15	26.6	-3	1.051	0.5	0.4	0	43	33.1	0	134	110	0	34	33	34
2025	10	26	4	2	15	25.3	-3.5	1.051	0.4	0.3	0	42.6	33.1	0	134	110	0	35	33	34
2025	10	26	4	12	15	25	-4.7	1.05	0.3	0.2	0	37.4	33.1	0	121	110	0	34	33	34
2025	10	26	4	22	15	25.3	-3.4	1.05	0.4	0.3	0	43	33.5	0	135	111	0	35	33	35
2025	10	26	4	32	15	25.6	-3	1.05	0.3	0.2	0	42.6	33.1	0	134	110	0	35	33	34
2025	10	26	4	42	15	24.3	-2.3	1.05	0.4	0.3	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	26	4	52	15	26.4	-2.3	1.049	0.4	0.3	0	42.6	33.1	0	134	110	0	35	33	33
2025	10	26	5	2	15	25.4	-2.8	1.049	0.4	0.3	0	43	33.1	0	134	110	0	34	33	34
2025	10	26	5	12	15	26	-2.1	1.049	0.3	0.2	0	42.6	33.1	0	134	110	0	35	33	34
2025	10	26	5	22	15	25.6	-2.2	1.049	0.5	0.4	0	42.6	33.1	0	134	110	0	35	33	34
2025	10	26	5	32	15	26.2	-3.1	1.049	0.4	0.3	0	43	33.1	0	134	110	0	34	33	34
2025	10	26	5	42	15	25.4	-2.5	1.048	0.5	0.4	0	42.6	33.1	0	134	110	0	35	33	34
2025	10	26	5	52	15	25.3	-3	1.048	0.5	0.4	0	42.6	32.7	0	133	109	0	34	33	34
2025	10	26	6	2	15	25.1	-2.5	1.048	0.4	0.3	0	42.6	32.7	0	134	110	0	35	34	34
2025	10	26	6	12	15	25.9	-2.5	1.048	0.3	0.2	0	41.7	32.7	0	132	109	0	35	33	34
2025	10	26	6	22	15	25.6	-3	1.047	0.5	0.4	0	42.6	32.7	0	134	110	0	35	34	34
2025	10	26	6	32	15	26.1	-2.5	1.048	0.3	0.2	0	42.6	32.3	0	133	109	0	34	34	34
2025	10	26	6	42	15	25.9	-2.3	1.047	0.3	0.2	0	42.1	32.7	0	133	109	0	35	33	34
2025	10	26	6	52	15	26.9	-2.8	1.048	0.5	0.4	0	42.6	32.3	0	133	109	0	34	34	34
2025	10	26	7	2	15	25.8	-2.5	1.047	0.4	0.3	0	42.6	32.3	0	133	109	0	34	34	34
2025	10	26	7	12	15	26.2	-2.6	1.048	0.3	0.2	0	41.7	32.7	0	132	109	0	35	33	34
2025	10	26	7	22	15	26	-2.9	1.048	0.4	0.3	0	41.7	31.8	0	132	108	0	35	34	34
2025	10	26	7	32	15	26	-3.4	1.048	0.5	0.4	0	41.3	31.4	0	131	107	0	35	34	34
2025	10	26	7	42	15	25.6	-2.4	1.047	0.5	0.4	0	41.3	31.4	0	130	106	0	34	33	35
2025	10	26	7	52	15	25.5	-3.5	1.048	0.4	0.3	0	41.3	31	0	130	106	0	34	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	26	8	2	15	24.5	-2.9	1.048	0.3	0.2	0	41.3	31.4	0	130	106	0	34	33	34
2025	10	26	8	12	15	25.5	-2.5	1.047	0.5	0.4	0	40.9	30.5	0	129	105	0	34	34	34
2025	10	26	8	22	15	26.2	-3	1.048	0.4	0.3	0	40.4	30.5	0	129	105	0	35	34	34
2025	10	26	8	32	15	25.6	-2	1.047	0.5	0.4	0	40.4	30.1	0	128	104	0	34	34	34
2025	10	26	8	42	15	26	-2.5	1.047	0.4	0.3	0	40.9	31	0	129	105	0	34	33	35
2025	10	26	8	52	15	26.2	-2.5	1.047	0.5	0.4	0	40	31	0	128	105	0	35	33	34
2025	10	26	9	2	15	25.5	-2.5	1.048	0.5	0.5	0	40	30.1	0	128	104	0	35	34	34
2025	10	26	9	12	15	24.2	-2.9	1.048	0.5	0.4	0	40	31	0	128	105	0	35	33	34
2025	10	26	9	22	15	24.9	-2.8	1.047	0.4	0.3	0	40.4	30.5	0	128	104	0	34	33	34
2025	10	26	9	32	15	26.4	-3.1	1.047	0.4	0.3	0	39.6	30.5	0	127	104	0	35	33	34
2025	10	26	9	42	15	25.8	-2	1.047	0.3	0.2	0	40	31	0	128	105	0	35	33	34
2025	10	26	9	52	15	24	-2.9	1.047	0.5	0.4	0	40.4	31	0	128	105	0	34	33	34
2025	10	26	10	2	15	25.7	-3.6	1.047	0.5	0.4	0	40.4	30.5	0	128	105	0	34	34	34
2025	10	26	10	12	15	25.2	-2.1	1.047	0.4	0.3	0	39.6	31	0	126	104	0	34	32	34
2025	10	26	10	22	15	25.3	-2.2	1.048	0.4	0.3	0	40	30.5	0	127	104	0	34	33	34
2025	10	26	10	32	15	25.3	-2.1	1.047	0.5	0.4	0	39.1	29.7	0	126	103	0	35	34	34
2025	10	26	10	42	15	25.3	-2.9	1.047	0.5	0.4	0	40.4	30.5	0	128	105	0	34	34	34
2025	10	26	10	52	15	24.7	-3.7	1.047	0.5	0.5	0	40.4	30.5	0	128	105	0	34	34	34
2025	10	26	11	2	15	24.6	-2.8	1.047	0.4	0.3	0	40.4	31.4	0	129	106	0	35	33	35
2025	10	26	11	12	15	25.4	-2.9	1.048	0.4	0.3	0	40.9	31	0	128	105	0	33	33	34
2025	10	26	11	22	15	25.2	-2.6	1.047	0.3	0.2	0	40.4	31	0	128	105	0	34	33	35
2025	10	26	11	32	15	24.7	-2.4	1.047	0.4	0.3	0	40.4	31	0	128	105	0	34	33	34
2025	10	26	11	42	15	25	-3	1.048	0.3	0.2	0	40	30.1	0	127	104	0	34	34	34
2025	10	26	11	52	15	24.8	-3.6	1.047	0.4	0.3	0	40	31	0	128	105	0	35	33	34
2025	10	26	12	2	15	25.3	-2.3	1.047	0.4	0.3	0	40	31	0	128	105	0	35	33	34
2025	10	26	12	12	15	25	-2.5	1.047	0.4	0.3	0	39.6	31	0	127	105	0	35	33	34
2025	10	26	12	22	15	25	-2.8	1.047	0.4	0.3	0	40.4	31.4	0	128	106	0	34	33	34
2025	10	26	12	32	15	25.4	-2.4	1.048	0.4	0.3	0	40.4	30.5	0	128	105	0	34	34	34
2025	10	26	12	42	15	24.7	-2.2	1.047	0.5	0.4	0	40	31	0	128	105	0	35	33	34
2025	10	26	12	52	15	25.4	-2.7	1.048	0.4	0.3	0	40	30.5	0	127	104	0	34	33	34
2025	10	26	13	2	15	25.5	-1.5	1.047	0.3	0.2	0	39.6	30.1	0	127	104	0	35	34	34
2025	10	26	13	12	15	25	-2.9	1.047	0.3	0.2	0	40	31	0	127	105	0	34	33	34
2025	10	26	13	22	15	25.5	-3	1.047	0.4	0.3	0	39.6	31	0	127	105	0	35	33	34
2025	10	26	13	32	15	24.7	-1.9	1.047	0.4	0.3	0	39.6	30.5	0	126	104	0	34	33	34
2025	10	26	13	42	15	25.2	-2.1	1.047	0.5	0.4	0	40	30.5	0	127	104	0	34	33	34
2025	10	26	13	52	15	24.6	-3.1	1.047	0.4	0.3	0	39.1	30.1	0	126	104	0	35	34	35
2025	10	26	14	2	15	24.1	-3	1.047	0.4	0.3	0	40	31	0	127	105	0	34	33	34
2025	10	26	14	12	15	24.2	-2.6	1.047	0.5	0.5	0	40	31	0	127	105	0	34	33	34
2025	10	26	14	22	15	25.3	-1.2	1.047	0.4	0.3	0	39.6	31	0	127	105	0	35	33	33
2025	10	26	14	32	15	24.6	-1.3	1.046	0.3	0.2	0	39.1	30.1	0	126	104	0	35	34	35
2025	10	26	14	42	15	24.2	-2.4	1.047	0.3	0.2	0	39.1	30.1	0	126	104	0	35	34	35
2025	10	26	14	52	15	23.6	-2.9	1.046	0.4	0.3	0	40	31	0	127	105	0	34	33	34
2025	10	26	15	2	15	24.2	-1.7	1.045	0.4	0.3	0	40	30.5	0	127	105	0	34	34	34
2025	10	26	15	12	15	25	-2.2	1.046	0.4	0.3	0	40	31	0	127	105	0	34	33	34
2025	10	26	15	22	15	25.2	-3	1.046	0.5	0.5	0	40.4	31.4	0	129	106	0	35	33	34
2025	10	26	15	32	15	25.5	-1.9	1.045	0.4	0.3	0	40	31.4	0	128	106	0	35	33	34
2025	10	26	15	42	15	25.8	-2.1	1.046	0.3	0.2	0	40	31	0	127	105	0	34	33	34
2025	10	26	15	52	15	24.6	-2.8	1.045	0.3	0.2	0	39.6	31	0	127	105	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	26	16	2	15	24.6	-3	1.045	0.5	0.5	0	40	31.4	0	128	106	0	35	33	34
2025	10	26	16	12	15	25.2	-3	1.045	0.4	0.3	0	40.4	31	0	128	106	0	34	34	34
2025	10	26	16	22	15	24	-2.5	1.045	0.4	0.3	0	40.4	31	0	128	106	0	34	34	34
2025	10	26	16	32	15	25	-2.2	1.045	0.4	0.3	0	40.4	31.4	0	128	106	0	34	33	34
2025	10	26	16	42	15	25.5	-1.3	1.045	0.5	0.4	0	40.4	31	0	128	105	0	34	33	34
2025	10	26	16	52	15	24.6	-2.6	1.044	0.4	0.3	0	40.4	31	0	128	105	0	34	33	35
2025	10	26	17	2	15	25	-2.6	1.044	0.5	0.4	0	39.6	31.4	0	127	105	0	35	32	34
2025	10	26	17	12	15	26.1	-3	1.045	0.5	0.4	0	40	30.1	0	127	104	0	34	34	34
2025	10	26	17	22	15	25.3	-3.5	1.045	0.4	0.3	0	40.4	31	0	128	104	0	34	32	34
2025	10	26	17	32	15	25	-1.8	1.045	0.4	0.3	0	40	31	0	128	105	0	35	33	34
2025	10	26	17	42	15	25.3	-2.8	1.045	0.5	0.5	0	40	31	0	128	105	0	35	33	34
2025	10	26	17	52	15	25.8	-2.6	1.045	0.5	0.4	0	40.9	31	0	129	105	0	34	33	34
2025	10	26	18	2	15	25.3	-3	1.045	0.4	0.3	0	40	31	0	128	105	0	35	33	34
2025	10	26	18	12	15	24.9	-3	1.045	0.4	0.3	0	40.9	31	0	129	106	0	34	34	35
2025	10	26	18	22	15	25.6	-3.3	1.045	0.3	0.2	0	40.4	31	0	129	106	0	35	34	34
2025	10	26	18	32	15	26.2	-3.8	1.044	0.4	0.3	0	40.4	31	0	129	106	0	35	34	34
2025	10	26	18	42	15	25.4	-2.5	1.045	0.4	0.3	0	41.7	32.3	0	131	108	0	34	33	34
2025	10	26	18	52	15	25.2	-2.1	1.045	0.4	0.3	0	41.7	32.7	0	132	109	0	35	33	34
2025	10	26	19	2	15	25.4	-2.8	1.045	0.5	0.5	0	42.6	32.7	0	132	109	0	33	33	34
2025	10	26	19	12	15	25	-2.4	1.045	0.4	0.3	0	41.3	33.1	0	131	110	0	35	33	34
2025	10	26	19	22	15	25.1	-2.8	1.044	0.3	0.2	0	42.6	33.1	0	133	110	0	34	33	34
2025	10	26	19	32	15	25.3	-1.8	1.044	0.4	0.3	0	43.4	33.1	0	135	110	0	34	33	33
2025	10	26	19	42	15	26.1	-2.5	1.044	0.3	0.2	0	43	33.1	0	134	110	0	34	33	34
2025	10	26	19	52	15	25.3	-4.1	1.044	0.3	0.2	0	42.6	32.3	0	133	109	0	34	34	34
2025	10	26	20	2	15	26	-2.9	1.044	0.5	0.4	0	43	33.1	0	134	110	0	34	33	34
2025	10	26	20	12	15	26	-2.5	1.044	0.5	0.4	0	43	33.1	0	134	110	0	34	33	34
2025	10	26	20	22	15	25.1	-2.5	1.044	0.5	0.4	0	42.6	33.1	0	134	111	0	35	34	34
2025	10	26	20	32	15	25.4	-3.1	1.044	0.5	0.4	0	43	33.5	0	135	111	0	35	33	34
2025	10	26	20	42	15	24.8	-3	1.044	0.4	0.3	0	43	32.7	0	134	110	0	34	34	34
2025	10	26	20	52	15	24.9	-2	1.044	0.3	0.2	0	43	33.5	0	134	111	0	34	33	34
2025	10	26	21	2	15	24.3	-3.3	1.044	0.5	0.4	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	26	21	12	15	24.6	-3.3	1.044	0.3	0.2	0	43	32.7	0	134	110	0	34	34	34
2025	10	26	21	22	15	25.3	-3.9	1.044	0.4	0.3	0	43	33.5	0	135	111	0	35	33	34
2025	10	26	21	32	15	25.5	-2.5	1.044	0.5	0.5	0	43.4	33.1	0	135	111	0	34	34	34
2025	10	26	21	42	15	27.2	-3.1	1.044	0.3	0.2	0	42.6	33.1	0	134	110	0	35	33	34
2025	10	26	21	52	15	25.3	-3.2	1.043	0.4	0.3	0	43.4	34	0	135	112	0	34	33	34
2025	10	26	22	2	15	26.7	-3.1	1.043	0.4	0.3	0	43	33.1	0	134	111	0	34	34	34
2025	10	26	22	12	15	25.9	-2.3	1.043	0.5	0.4	0	43	33.5	0	134	111	0	34	33	34
2025	10	26	22	22	15	25.7	-2.7	1.043	0.3	0.2	0	43	33.5	0	135	112	0	35	34	35
2025	10	26	22	32	15	24.4	-2.5	1.043	0.4	0.3	0	43	33.5	0	135	111	0	35	33	34
2025	10	26	22	42	15	25.1	-2.3	1.043	0.5	0.5	0	43	33.5	0	135	111	0	35	33	34
2025	10	26	22	52	15	26.5	-3.4	1.043	0.5	0.4	0	43	33.5	0	134	111	0	34	33	34
2025	10	26	23	2	15	24.3	-2	1.043	0.3	0.2	0	43	33.1	0	134	111	0	34	34	34
2025	10	26	23	12	15	24.1	-2.3	1.043	0.4	0.3	0	43	33.1	0	135	111	0	35	34	34
2025	10	26	23	22	15	25.7	-2.8	1.043	0.4	0.3	0	42.6	33.5	0	134	111	0	35	33	35
2025	10	26	23	32	15	23.9	-3.1	1.043	0.3	0.2	0	41.7	33.1	0	131	111	0	34	34	34
2025	10	26	23	42	15	25.2	-2.5	1.043	0.5	0.4	0	43.4	33.5	0	136	111	0	35	33	34
2025	10	26	23	52	15	25.4	-2.5	1.043	0.4	0.3	0	43.9	33.1	0	136	110	0	34	33	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	27	0	2	15	25.8	-2.2	1.043	0.5	0.5	0	43.9	33.5	0	136	111	0	34	33	35
2025	10	27	0	12	15	26.5	-3.1	1.043	0.5	0.4	0	43.4	33.5	0	136	111	0	35	33	35
2025	10	27	0	22	15	25.6	-3.3	1.043	0.5	0.5	0	43.9	33.5	0	136	111	0	34	33	34
2025	10	27	0	32	15	25.4	-2.8	1.043	0.5	0.4	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	27	0	42	15	25.6	-2.4	1.042	0.3	0.2	0	43.9	32.7	0	136	110	0	34	34	34
2025	10	27	0	52	15	24.5	-1.7	1.043	0.4	0.3	0	43.4	33.1	0	136	111	0	35	34	34
2025	10	27	1	2	15	25.6	-3.4	1.043	0.5	0.4	0	43.4	33.1	0	135	110	0	34	33	34
2025	10	27	1	12	15	25	-3.8	1.043	0.3	0.2	0	43.4	33.5	0	136	111	0	35	33	34
2025	10	27	1	22	15	25.1	-2	1.042	0.4	0.3	0	43.4	33.1	0	135	110	0	34	33	35
2025	10	27	1	32	15	24.8	-2.5	1.042	0.4	0.3	0	43.9	33.5	0	136	111	0	34	33	34
2025	10	27	1	42	15	25.2	-3.2	1.042	0.5	0.4	0	43.4	33.1	0	135	110	0	34	33	34
2025	10	27	1	52	15	26.9	-3.2	1.042	0.3	0.2	0	43.4	33.1	0	135	110	0	34	33	34
2025	10	27	2	2	15	24.9	-2.8	1.042	0.4	0.3	0	43.4	33.5	0	136	111	0	35	33	34
2025	10	27	2	12	15	26	-2.9	1.042	0.4	0.3	0	43	33.1	0	135	110	0	35	33	34
2025	10	27	2	22	15	25.2	-3.4	1.042	0.4	0.3	0	43.4	33.1	0	135	111	0	34	34	34
2025	10	27	2	32	15	24.6	-1.8	1.042	0.4	0.3	0	43.9	33.5	0	136	111	0	34	33	35
2025	10	27	2	42	15	25.5	-3.5	1.042	0.4	0.3	0	43.4	33.1	0	136	111	0	35	34	34
2025	10	27	2	52	15	24.5	-2.4	1.042	0.5	0.4	0	43.4	33.1	0	136	111	0	35	34	34
2025	10	27	3	2	15	26	-2.4	1.042	0.5	0.4	0	43	33.1	0	135	110	0	35	33	35
2025	10	27	3	12	15	24.8	-2.6	1.042	0.5	0.4	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	27	3	22	15	24.3	-2.5	1.042	0.5	0.5	0	43	33.1	0	135	111	0	35	34	34
2025	10	27	3	32	15	25.7	-2.8	1.042	0.4	0.3	0	43.4	32.7	0	135	110	0	34	34	34
2025	10	27	3	42	15	25.6	-2.5	1.042	0.3	0.2	0	43.9	33.5	0	136	111	0	34	33	35
2025	10	27	3	52	15	25.8	-2.5	1.042	0.4	0.3	0	43	33.5	0	135	111	0	35	33	34
2025	10	27	4	2	15	25.2	-3.4	1.042	0.4	0.3	0	43.4	33.1	0	135	110	0	34	33	35
2025	10	27	4	12	15	25.5	-3.7	1.042	0.5	0.4	0	43.4	33.5	0	136	111	0	35	33	34
2025	10	27	4	22	15	24.5	-2.6	1.042	0.3	0.2	0	42.6	33.1	0	134	110	0	35	33	34
2025	10	27	4	32	15	23.8	-2.5	1.042	0.4	0.3	0	43	32.7	0	135	110	0	35	34	34
2025	10	27	4	42	15	25.3	-4.2	1.042	0.4	0.3	0	43	33.1	0	135	110	0	35	33	34
2025	10	27	4	52	15	26	-2.9	1.042	0.5	0.4	0	43	32.7	0	135	110	0	35	34	34
2025	10	27	5	2	15	25.5	-2.4	1.042	0.5	0.4	0	42.6	33.5	0	134	110	0	35	32	34
2025	10	27	5	12	15	25.6	-2.6	1.042	0.3	0.2	0	42.6	33.1	0	134	110	0	35	33	34
2025	10	27	5	22	15	25.6	-2.5	1.042	0.5	0.4	0	42.6	32.7	0	134	110	0	35	34	34
2025	10	27	5	32	15	24.7	-3	1.042	0.4	0.3	0	43	33.1	0	135	111	0	35	34	34
2025	10	27	5	42	15	25.2	-3	1.042	0.4	0.3	0	43	32.7	0	134	110	0	34	34	34
2025	10	27	5	52	15	25.3	-3	1.042	0.4	0.3	0	43.4	33.1	0	135	111	0	34	34	34
2025	10	27	6	2	15	24.3	-2	1.042	0.4	0.3	0	42.6	33.1	0	134	110	0	35	33	34
2025	10	27	6	12	15	26.6	-3.2	1.042	0.4	0.3	0	42.6	32.7	0	134	109	0	35	33	34
2025	10	27	6	22	15	25.6	-3.1	1.042	0.4	0.3	0	43	32.7	0	134	110	0	34	34	34
2025	10	27	6	32	15	24.2	-3	1.042	0.4	0.3	0	42.6	32.3	0	133	109	0	34	34	34
2025	10	27	6	42	15	25	-3	1.042	0.3	0.2	0	42.1	32.3	0	133	109	0	35	34	34
2025	10	27	6	52	15	25.5	-2.9	1.042	0.4	0.3	0	42.1	32.3	0	133	109	0	35	34	34
2025	10	27	7	2	15	25.6	-2.7	1.042	0.5	0.4	0	42.1	32.3	0	133	109	0	35	34	34
2025	10	27	7	12	15	25.7	-3.3	1.042	0.4	0.3	0	42.1	31.8	0	132	108	0	34	34	34
2025	10	27	7	22	15	24.7	-3	1.042	0.4	0.3	0	42.1	32.3	0	132	108	0	34	33	34
2025	10	27	7	32	15	25.3	-3.2	1.042	0.5	0.4	0	41.7	31.8	0	131	107	0	34	33	34
2025	10	27	7	42	15	24.7	-2.9	1.042	0.4	0.3	0	41.7	31.8	0	131	107	0	34	33	34
2025	10	27	7	52	15	25.2	-3.3	1.042	0.4	0.3	0	41.7	31.8	0	131	107	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	27	8	2	15	26	-3.2	1.042	0.5	0.5	0	40.9	31.8	0	130	107	0	35	33	34
2025	10	27	8	12	15	24.6	-1.2	1.042	0.3	0.2	0	40.9	31.8	0	130	107	0	35	33	34
2025	10	27	8	22	15	24.2	-3.7	1.042	0.4	0.3	0	41.7	32.3	0	131	108	0	34	33	34
2025	10	27	8	32	15	25.7	-3	1.042	0.3	0.2	0	41.3	31.4	0	130	107	0	34	34	34
2025	10	27	8	42	15	25.2	-3	1.042	0.4	0.3	0	40.9	31.4	0	129	106	0	34	33	34
2025	10	27	8	52	15	26.2	-3	1.042	0.3	0.2	0	40.4	31.4	0	129	106	0	35	33	34
2025	10	27	9	2	15	24.9	-2	1.042	0.3	0.2	0	40.9	31	0	129	106	0	34	34	35
2025	10	27	9	12	15	25.5	-3.2	1.043	0.4	0.3	0	40.9	31.4	0	129	106	0	34	33	35
2025	10	27	9	22	15	25	-3.4	1.043	0.3	0.2	0	40.4	31	0	129	106	0	35	34	34
2025	10	27	9	32	15	24.9	-3.1	1.043	0.3	0.2	0	41.3	32.3	0	131	108	0	35	33	33
2025	10	27	9	42	15	26.1	-4	1.043	0.4	0.3	0	40	31	0	128	105	0	35	33	34
2025	10	27	9	52	15	25.3	-2.9	1.043	0.3	0.2	0	40.4	31	0	128	105	0	34	33	34
2025	10	27	10	2	15	25.3	-2.5	1.043	0.4	0.3	0	40	30.5	0	128	105	0	35	34	34
2025	10	27	10	12	15	25.5	-3	1.043	0.4	0.3	0	40.4	31.8	0	129	106	0	35	32	34
2025	10	27	10	22	15	24.4	-2.4	1.043	0.5	0.4	0	40.4	32.3	0	129	107	0	35	32	34
2025	10	27	10	32	15	26	-3.4	1.043	0.4	0.3	0	40	30.5	0	128	105	0	35	34	34
2025	10	27	10	42	15	24.9	-2.9	1.043	0.4	0.3	0	40.4	31	0	128	105	0	34	33	35
2025	10	27	10	52	15	25.4	-2.2	1.043	0.5	0.4	0	40	31	0	128	106	0	35	34	34
2025	10	27	11	2	15	25.6	-3.3	1.043	0.4	0.3	0	40	31	0	128	105	0	35	33	33
2025	10	27	11	12	15	24.9	-3	1.043	0.5	0.4	0	40	31	0	128	105	0	35	33	34
2025	10	27	11	22	15	26.1	-2.8	1.043	0.4	0.3	0	41.3	31.4	0	130	107	0	34	34	34
2025	10	27	11	32	15	25.3	-2.6	1.043	0.5	0.4	0	40.4	31.4	0	128	106	0	34	33	34
2025	10	27	11	42	15	24.1	-2	1.043	0.3	0.2	0	40.9	31.4	0	130	107	0	35	34	34
2025	10	27	11	52	15	24.8	-3.3	1.043	0.4	0.3	0	40	31	0	128	105	0	35	33	34
2025	10	27	12	2	15	26.7	-3.6	1.043	0.4	0.3	0	40.4	31	0	128	105	0	34	33	34
2025	10	27	12	12	15	25.1	-1.8	1.043	0.4	0.3	0	40.9	31	0	129	106	0	34	34	34
2025	10	27	12	22	15	25.1	-1.8	1.043	0.5	0.4	0	41.3	31.8	0	130	107	0	34	33	35
2025	10	27	12	32	15	26.5	-2.9	1.043	0.5	0.4	0	41.3	32.3	0	131	108	0	35	33	34
2025	10	27	12	42	15	26.2	-2.7	1.043	0.3	0.2	0	41.3	31.8	0	130	107	0	34	33	33
2025	10	27	12	52	15	24.9	-4	1.043	0.3	0.2	0	40.9	31	0	129	106	0	34	34	33
2025	10	27	13	2	15	26.8	-3.4	1.042	0.4	0.3	0	40.4	31.4	0	129	106	0	35	33	34
2025	10	27	13	12	15	25.5	-3.6	1.043	0.5	0.4	0	40.9	31.4	0	129	107	0	34	34	34
2025	10	27	13	22	15	25.5	-3.3	1.042	0.4	0.3	0	41.3	31.8	0	130	107	0	34	33	34
2025	10	27	13	32	15	25.2	-3.9	1.042	0.4	0.3	0	40.9	32.3	0	130	108	0	35	33	35
2025	10	27	13	42	15	25.4	-2.7	1.043	0.4	0.3	0	41.7	32.3	0	132	109	0	35	34	34
2025	10	27	13	52	15	25.5	-2.3	1.042	0.3	0.2	0	41.7	32.3	0	131	108	0	34	33	35
2025	10	27	14	2	15	23.9	-2.4	1.042	0.5	0.4	0	41.3	32.3	0	131	108	0	35	33	34
2025	10	27	14	12	15	24.5	-3.6	1.042	0.3	0.2	0	41.7	31.8	0	131	107	0	34	33	34
2025	10	27	14	22	15	24.7	-2.7	1.042	0.4	0.3	0	41.7	31.8	0	131	108	0	34	34	34
2025	10	27	14	32	15	26.4	-2.6	1.042	0.5	0.4	0	41.3	31.8	0	130	107	0	34	33	35
2025	10	27	14	42	15	25.5	-3	1.042	0.5	0.5	0	41.3	31.8	0	130	107	0	34	33	34
2025	10	27	14	52	15	25.4	-2.5	1.042	0.4	0.3	0	40.9	31.8	0	129	107	0	34	33	34
2025	10	27	15	2	15	24.1	-3.5	1.042	0.4	0.3	0	41.7	31.8	0	131	107	0	34	33	34
2025	10	27	15	12	15	26.4	-3	1.042	0.4	0.3	0	41.7	31.8	0	131	107	0	34	33	34
2025	10	27	15	22	15	25.2	-3.4	1.041	0.3	0.2	0	41.7	32.3	0	132	108	0	35	33	34
2025	10	27	15	32	15	25.5	-3.4	1.041	0.3	0.2	0	42.1	32.3	0	132	108	0	34	33	34
2025	10	27	15	42	15	25.1	-3.8	1.039	0.5	0.4	0	41.7	31.8	0	131	108	0	34	34	33
2025	10	27	15	52	15	25	-2.1	1.039	0.4	0.3	0	42.1	32.7	0	132	109	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	27	16	2	15	25.2	-3.2	1.039	0.3	0.2	0	42.1	31.8	0	132	108	0	34	34	35
2025	10	27	16	12	15	24.8	-3.8	1.039	0.4	0.3	0	41.7	31.8	0	131	107	0	34	33	33
2025	10	27	16	22	15	25.1	-1.7	1.039	0.4	0.3	0	41.7	31.8	0	131	107	0	34	33	34
2025	10	27	16	32	15	25.4	-3.5	1.039	0.4	0.3	0	40.9	31.4	0	130	106	0	35	33	34
2025	10	27	16	42	15	25.2	-3.7	1.038	0.5	0.4	0	41.3	31	0	130	106	0	34	34	35
2025	10	27	16	52	15	25	-2.6	1.04	0.3	0.2	0	41.3	31	0	131	106	0	35	34	34
2025	10	27	17	2	15	24.6	-2.6	1.04	0.5	0.4	0	41.7	31.4	0	131	106	0	34	33	35
2025	10	27	17	12	15	26.2	-3.3	1.039	0.4	0.3	0	40.9	30.5	0	130	105	0	35	34	35
2025	10	27	17	22	15	26.3	-4	1.039	0.4	0.3	0	41.3	31	0	130	105	0	34	33	34
2025	10	27	17	32	15	24.8	-2	1.04	0.4	0.3	0	40.9	31	0	130	105	0	35	33	34
2025	10	27	17	42	15	24.8	-2.2	1.039	0.4	0.3	0	41.3	31	0	130	105	0	34	33	34
2025	10	27	17	52	15	24.9	-3.6	1.039	0.3	0.2	0	41.3	30.5	0	131	105	0	35	34	34
2025	10	27	18	2	15	26.3	-3.1	1.039	0.3	0.2	0	41.3	30.5	0	130	105	0	34	34	34
2025	10	27	18	12	15	25.7	-3.2	1.039	0.4	0.3	0	41.3	31.4	0	131	106	0	35	33	34
2025	10	27	18	22	15	26.4	-2.6	1.039	0.5	0.4	0	42.1	31.4	0	132	106	0	34	33	34
2025	10	27	18	32	15	24.7	-3.2	1.039	0.4	0.3	0	42.6	32.3	0	133	108	0	34	33	34
2025	10	27	18	42	15	27.1	-3.6	1.039	0.3	0.2	0	42.6	32.7	0	134	109	0	35	33	34
2025	10	27	18	52	15	25.7	-3	1.039	0.4	0.3	0	43.4	33.5	0	136	110	0	35	32	33
2025	10	27	19	2	15	26.2	-3	1.04	0.3	0.2	0	43.4	33.1	0	135	110	0	34	33	34
2025	10	27	19	12	15	26.4	-3.4	1.039	0.5	0.4	0	43.4	33.1	0	135	110	0	34	33	34
2025	10	27	19	22	15	25.1	-3	1.039	0.4	0.3	0	43.9	33.1	0	136	110	0	34	33	34
2025	10	27	19	32	15	25.8	-2.1	1.04	0.5	0.4	0	43.9	33.1	0	136	111	0	34	34	34
2025	10	27	19	42	15	24.5	-2.6	1.04	0.4	0.3	0	43.4	33.5	0	136	111	0	35	33	34
2025	10	27	19	52	15	24.9	-2.6	1.04	0.3	0.2	0	43.9	33.1	0	136	111	0	34	34	35
2025	10	27	20	2	15	26.4	-3	1.039	0.5	0.4	0	43.4	33.1	0	136	111	0	35	34	34
2025	10	27	20	12	15	25.6	-3	1.039	0.5	0.4	0	43.4	34	0	136	111	0	35	32	34
2025	10	27	20	22	15	24.9	-3	1.039	0.3	0.2	0	43.9	33.5	0	136	111	0	34	33	34
2025	10	27	20	32	15	25.3	-3.3	1.039	0.5	0.4	0	43.4	33.1	0	136	111	0	35	34	34
2025	10	27	20	42	15	25.3	-3.4	1.039	0.5	0.4	0	43.9	33.1	0	136	111	0	34	34	34
2025	10	27	20	52	15	25	-3	1.04	0.5	0.4	0	43.9	33.5	0	136	111	0	34	33	34
2025	10	27	21	2	15	26.2	-3	1.04	0.4	0.3	0	43.9	33.5	0	136	111	0	34	33	34
2025	10	27	21	12	15	24.5	-2.6	1.039	0.6	0.5	0	43.4	33.5	0	136	111	0	35	33	34
2025	10	27	21	22	15	26.6	-2.9	1.039	0.5	0.4	0	43.4	33.5	0	136	111	0	35	33	34
2025	10	27	21	32	15	25.4	-4.1	1.039	0.4	0.3	0	43.4	33.5	0	135	110	0	34	32	34
2025	10	27	21	42	15	25.4	-2.5	1.039	0.5	0.4	0	43.4	33.5	0	136	111	0	35	33	34
2025	10	27	21	52	15	25.2	-3.8	1.039	0.4	0.3	0	43.4	33.1	0	135	111	0	34	34	34
2025	10	27	22	2	15	24.7	-2.5	1.039	0.3	0.2	0	43	33.5	0	135	111	0	35	33	34
2025	10	27	22	12	15	24.5	-2.9	1.039	0.5	0.4	0	43.4	33.5	0	136	111	0	35	33	35
2025	10	27	22	22	15	24.9	-2.8	1.039	0.4	0.3	0	43.9	34	0	136	112	0	34	33	34
2025	10	27	22	32	15	25.2	-2.6	1.039	0.5	0.5	0	43.9	33.5	0	136	111	0	34	33	34
2025	10	27	22	42	15	25.1	-3.1	1.039	0.3	0.2	0	43	33.1	0	135	111	0	35	34	34
2025	10	27	22	52	15	25.1	-2.6	1.039	0.5	0.4	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	27	23	2	15	25.1	-2.8	1.038	0.4	0.3	0	43.4	34	0	136	112	0	35	33	34
2025	10	27	23	12	15	25.1	-2	1.039	0.4	0.3	0	43.4	33.5	0	136	111	0	35	33	34
2025	10	27	23	22	15	24.7	-2.2	1.039	0.5	0.4	0	43.4	34	0	136	112	0	35	33	35
2025	10	27	23	32	15	26.1	-1.9	1.039	0.3	0.2	0	43.4	33.1	0	136	111	0	35	34	34
2025	10	27	23	42	15	25.8	-3	1.039	0.5	0.4	0	43.9	34	0	136	112	0	34	33	34
2025	10	27	23	52	15	25.8	-1.7	1.039	0.5	0.5	0	43.4	33.5	0	136	111	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	28	0	2	15	25.4	-2.5	1.039	0.4	0.3	0	43	33.5	0	135	111	0	35	33	34
2025	10	28	0	12	15	25.9	-3	1.039	0.5	0.5	0	43.4	33.5	0	135	111	0	34	33	34
2025	10	28	0	22	15	25	-2.9	1.039	0.4	0.3	0	43	32.7	0	135	111	0	35	35	34
2025	10	28	0	32	15	25.5	-2.6	1.039	0.4	0.3	0	43.9	34	0	136	112	0	34	33	34
2025	10	28	0	42	15	23.8	-2.6	1.039	0.5	0.4	0	43.9	34	0	137	112	0	35	33	34
2025	10	28	0	52	15	25.3	-2.5	1.039	0.3	0.2	0	43.4	33.1	0	136	111	0	35	34	34
2025	10	28	1	2	15	25.2	-3	1.039	0.4	0.3	0	43	33.1	0	135	111	0	35	34	34
2025	10	28	1	12	15	24.3	-3	1.039	0.4	0.3	0	43.9	33.5	0	136	112	0	34	34	34
2025	10	28	1	22	15	25.1	-2.1	1.039	0.5	0.4	0	43.4	33.1	0	135	111	0	34	34	35
2025	10	28	1	32	15	25.3	-3.5	1.039	0.4	0.3	0	43	33.5	0	135	111	0	35	33	34
2025	10	28	1	42	15	26.2	-3.8	1.039	0.4	0.3	0	43	33.1	0	135	111	0	35	34	34
2025	10	28	1	52	15	25.2	-2.5	1.039	0.4	0.3	0	43.4	33.1	0	135	110	0	34	33	34
2025	10	28	2	2	15	24.5	-2.7	1.039	0.5	0.5	0	43.9	33.1	0	136	110	0	34	33	34
2025	10	28	2	12	15	25.4	-2	1.039	0.3	0.2	0	43.9	33.1	0	137	111	0	35	34	34
2025	10	28	2	22	15	25.1	-2.2	1.039	0.5	0.4	0	44.7	33.5	0	138	112	0	34	34	34
2025	10	28	2	32	15	24.9	-4.8	1.039	0.4	0.3	0	43.4	33.1	0	136	110	0	35	33	34
2025	10	28	2	42	15	25.6	-3.4	1.039	0.5	0.4	0	43.4	33.5	0	136	111	0	35	33	34
2025	10	28	2	52	15	24.6	-2.2	1.039	0.4	0.3	0	43.4	33.1	0	136	111	0	35	34	34
2025	10	28	3	2	15	24.8	-3	1.039	0.4	0.3	0	44.3	32.7	0	137	110	0	34	34	34
2025	10	28	3	12	15	26.7	-2.9	1.039	0.5	0.5	0	43.9	33.5	0	137	111	0	35	33	34
2025	10	28	3	22	15	24.6	-2.7	1.039	0.4	0.3	0	44.3	33.1	0	137	111	0	34	34	34
2025	10	28	3	32	15	25	-2.7	1.039	0.4	0.3	0	44.3	33.5	0	137	111	0	34	33	35
2025	10	28	3	42	15	25	-2.3	1.039	0.3	0.2	0	44.3	33.1	0	137	110	0	34	33	34
2025	10	28	3	52	15	25.5	-3.2	1.039	0.4	0.3	0	43.4	33.1	0	136	110	0	35	33	35
2025	10	28	4	2	15	25	-2.2	1.039	0.5	0.4	0	43.4	33.1	0	136	110	0	35	33	34
2025	10	28	4	12	15	24.4	-2.8	1.039	0.5	0.4	0	43.9	33.1	0	136	110	0	34	33	34
2025	10	28	4	22	15	25.5	-3.1	1.039	0.3	0.2	0	43	32.7	0	135	109	0	35	33	34
2025	10	28	4	32	15	25.4	-2.8	1.039	0.5	0.4	0	43.4	33.1	0	136	110	0	35	33	34
2025	10	28	4	42	15	26.1	-3.2	1.039	0.5	0.4	0	44.3	32.7	0	137	110	0	34	34	35
2025	10	28	4	52	15	24.7	-2.8	1.039	0.3	0.2	0	43.4	32.7	0	136	110	0	35	34	34
2025	10	28	5	2	15	25.5	-3.1	1.039	0.5	0.4	0	43.4	32.7	0	136	110	0	35	34	34
2025	10	28	5	12	15	25	-3.4	1.039	0.4	0.3	0	43.4	32.7	0	136	110	0	35	34	34
2025	10	28	5	22	15	25.5	-2	1.039	0.3	0.2	0	43.9	32.7	0	136	110	0	34	34	35
2025	10	28	5	32	15	25.2	-2.5	1.039	0.4	0.3	0	43.9	32.3	0	136	109	0	34	34	35
2025	10	28	5	42	15	24.6	-3.6	1.039	0.3	0.2	0	43.4	32.7	0	135	110	0	34	34	34
2025	10	28	5	52	15	25.4	-3	1.039	0.5	0.4	0	43.4	32.3	0	135	109	0	34	34	34
2025	10	28	6	2	15	25.4	-2	1.039	0.3	0.2	0	43	32.7	0	135	109	0	35	33	34
2025	10	28	6	12	15	24.6	-2.5	1.039	0.4	0.3	0	43	32.7	0	135	109	0	35	33	34
2025	10	28	6	22	15	25	-3.2	1.039	0.4	0.3	0	43	32.7	0	135	109	0	35	33	34
2025	10	28	6	32	15	24.5	-3.2	1.039	0.3	0.2	0	43	32.7	0	135	109	0	35	33	35
2025	10	28	6	42	15	25.6	-2.5	1.039	0.5	0.4	0	42.6	32.7	0	134	109	0	35	33	34
2025	10	28	6	52	15	25.2	-4.1	1.039	0.4	0.3	0	42.6	32.3	0	134	109	0	35	34	34
2025	10	28	7	2	15	27	-3.4	1.039	0.5	0.4	0	42.6	32.3	0	133	108	0	34	33	33
2025	10	28	7	12	15	24.9	-1.7	1.04	0.4	0.3	0	42.6	32.3	0	133	108	0	34	33	34
2025	10	28	7	22	15	25.4	-3	1.04	0.5	0.4	0	42.1	31.8	0	133	107	0	35	33	34
2025	10	28	7	32	15	26	-2.5	1.039	0.5	0.4	0	48.6	37.4	0	147	121	0	34	34	35
2025	10	28	7	42	15	25.9	-2.5	1.04	0.4	0.3	0	43.4	33.5	0	136	111	0	35	33	34
2025	10	28	7	52	15	26.4	-3	1.04	0.4	0.3	0	42.1	32.3	0	133	108	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	28	8	2	15	26.9	-3	1.04	0.3	0.2	0	42.1	31.8	0	132	107	0	34	33	34
2025	10	28	8	12	15	25.1	-2.6	1.04	0.5	0.4	0	42.1	31.8	0	133	107	0	35	33	35
2025	10	28	8	22	15	24.6	-3.4	1.04	0.4	0.3	0	42.1	32.3	0	132	108	0	34	33	34
2025	10	28	8	32	15	26	-2.1	1.04	0.3	0.2	0	41.7	31.4	0	132	107	0	35	34	34
2025	10	28	8	42	15	24.7	-2.3	1.04	0.4	0.3	0	41.3	31.4	0	131	106	0	35	33	34
2025	10	28	8	52	15	25.9	-2	1.04	0.3	0.2	0	41.3	31.8	0	131	107	0	35	33	34
2025	10	28	9	2	15	25.4	-3	1.04	0.5	0.4	0	42.1	31.4	0	132	107	0	34	34	35
2025	10	28	9	12	15	25	-2.6	1.04	0.3	0.2	0	41.3	31	0	131	106	0	35	34	34
2025	10	28	9	22	15	25.5	-2.7	1.04	0.3	0.2	0	41.3	31.8	0	131	107	0	35	33	34
2025	10	28	9	32	15	25.5	-3.2	1.04	0.5	0.4	0	41.3	31.4	0	131	106	0	35	33	34
2025	10	28	9	42	15	24.4	-3.4	1.04	0.4	0.3	0	40.9	31	0	130	105	0	35	33	34
2025	10	28	9	52	15	26.7	-4.6	1.04	0.4	0.3	0	40.4	31.4	0	129	105	0	35	32	34
2025	10	28	10	2	15	24.7	-3.2	1.04	0.4	0.3	0	40.9	31.4	0	130	106	0	35	33	34
2025	10	28	10	12	15	25	-3	1.04	0.3	0.2	0	41.3	31	0	130	106	0	34	34	34
2025	10	28	10	22	15	24.9	-3.3	1.041	0.3	0.2	0	41.3	31.4	0	130	106	0	34	33	34
2025	10	28	10	32	15	24.5	-3.4	1.041	0.4	0.3	0	41.7	31.4	0	131	107	0	34	34	34
2025	10	28	10	42	15	25.6	-3	1.041	0.5	0.4	0	42.1	32.3	0	132	108	0	34	33	35
2025	10	28	10	52	15	25.1	-2.6	1.04	0.4	0.3	0	41.7	31.8	0	131	107	0	34	33	34
2025	10	28	11	2	15	25.8	-3.8	1.041	0.4	0.3	0	41.3	31.8	0	131	107	0	35	33	34
2025	10	28	11	12	15	24.7	-2.4	1.041	0.3	0.2	0	40.9	31	0	130	106	0	35	34	34
2025	10	28	11	22	15	24.9	-3.3	1.041	0.3	0.2	0	40.9	31.4	0	130	106	0	35	33	34
2025	10	28	11	32	15	25.5	-3	1.041	0.5	0.4	0	40.4	30.1	0	128	104	0	34	34	34
2025	10	28	11	42	15	25.3	-2.9	1.041	0.5	0.4	0	40.9	31	0	130	105	0	35	33	34
2025	10	28	11	52	15	24.6	-3	1.041	0.5	0.4	0	41.3	31	0	130	105	0	34	33	34
2025	10	28	12	2	15	25.5	-3.2	1.041	0.4	0.3	0	41.7	31.4	0	131	106	0	34	33	34
2025	10	28	12	12	15	25	-2.2	1.041	0.3	0.2	0	41.3	31	0	131	106	0	35	34	33
2025	10	28	12	22	15	24.6	-3	1.041	0.3	0.2	0	41.3	31	0	131	105	0	35	33	34
2025	10	28	12	32	15	25.4	-2.3	1.041	0.4	0.3	0	41.3	31	0	130	105	0	34	33	34
2025	10	28	12	42	15	24.9	-2.2	1.041	0.5	0.5	0	41.3	31.4	0	131	106	0	35	33	34
2025	10	28	12	52	15	25.3	-2.7	1.041	0.5	0.4	0	41.3	31	0	130	105	0	34	33	34
2025	10	28	13	2	15	24.9	-2.6	1.041	0.4	0.3	0	41.3	30.5	0	131	105	0	35	34	34
2025	10	28	13	12	15	24	-2.9	1.04	0.4	0.3	0	41.3	31.4	0	131	106	0	35	33	34
2025	10	28	13	22	15	24.2	-3.4	1.04	0.4	0.3	0	41.7	31	0	131	106	0	34	34	34
2025	10	28	13	32	15	24.5	-2.8	1.04	0.4	0.3	0	42.1	31	0	132	106	0	34	34	34
2025	10	28	13	42	15	26.8	-3	1.04	0.5	0.4	0	41.3	30.5	0	130	104	0	34	33	34
2025	10	28	13	52	15	26.3	-2.4	1.04	0.4	0.3	0	41.3	30.5	0	130	105	0	34	34	34
2025	10	28	14	2	15	25.3	-3.1	1.04	0.5	0.5	0	41.3	30.5	0	130	105	0	34	34	35
2025	10	28	14	12	15	26	-4.2	1.04	0.4	0.3	0	41.3	31	0	130	105	0	34	33	34
2025	10	28	14	22	15	25.8	-2.8	1.039	0.5	0.4	0	41.7	31	0	131	105	0	34	33	34
2025	10	28	14	32	15	24.4	-3.4	1.038	0.5	0.4	0	41.7	31	0	131	106	0	34	34	34
2025	10	28	14	42	15	25.3	-3.3	1.038	0.4	0.3	0	42.1	31.8	0	132	107	0	34	33	34
2025	10	28	14	52	15	25.7	-2.8	1.038	0.4	0.3	0	41.3	31.8	0	131	106	0	35	32	34
2025	10	28	15	2	15	25.3	-3.9	1.038	0.4	0.3	0	41.7	31	0	131	105	0	34	33	34
2025	10	28	15	12	15	26.2	-3.7	1.037	0.4	0.3	0	41.3	30.5	0	130	105	0	34	34	34
2025	10	28	15	22	15	24.8	-3.4	1.037	0.5	0.4	0	41.7	31	0	131	106	0	34	34	34
2025	10	28	15	32	15	24.5	-2.9	1.036	0.3	0.2	0	41.7	31	0	131	106	0	34	34	35
2025	10	28	15	42	15	25	-3	1.036	0.4	0.3	0	41.3	31.4	0	131	106	0	35	33	34
2025	10	28	15	52	15	24.9	-2.8	1.037	0.3	0.2	0	42.1	31.8	0	132	107	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	28	16	2	15	25.4	-3.4	1.037	0.4	0.3	0	42.1	31.4	0	132	106	0	34	33	34
2025	10	28	16	12	15	25.4	-3.4	1.036	0.5	0.4	0	42.1	31.4	0	132	106	0	34	33	34
2025	10	28	16	22	15	25.1	-2.8	1.036	0.5	0.4	0	42.1	31.4	0	132	106	0	34	33	34
2025	10	28	16	32	15	25.1	-1.7	1.037	0.4	0.3	0	41.3	31	0	131	105	0	35	33	34
2025	10	28	16	42	15	26	-3	1.037	0.4	0.3	0	41.7	30.5	0	131	105	0	34	34	34
2025	10	28	16	52	15	26.5	-2.4	1.036	0.5	0.4	0	41.7	31	0	131	105	0	34	33	34
2025	10	28	17	2	15	24.9	-3	1.036	0.5	0.4	0	42.1	31.4	0	132	106	0	34	33	34
2025	10	28	17	12	15	25.1	-2.6	1.036	0.4	0.3	0	41.7	31.4	0	131	106	0	34	33	34
2025	10	28	17	22	15	23.8	-2.3	1.036	0.4	0.3	0	41.3	31	0	131	105	0	35	33	33
2025	10	28	17	32	15	25.5	-1.7	1.036	0.3	0.2	0	41.7	31	0	131	105	0	34	33	33
2025	10	28	17	42	15	24.7	-3.5	1.036	0.5	0.4	0	41.7	31	0	131	105	0	34	33	34
2025	10	28	17	52	15	25.5	-2.9	1.036	0.3	0.2	0	41.7	30.5	0	131	104	0	34	33	35
2025	10	28	18	2	15	24.1	-2.6	1.036	0.4	0.3	0	41.7	31	0	132	105	0	35	33	34
2025	10	28	18	12	15	26.3	-2.5	1.036	0.5	0.4	0	41.3	31	0	131	105	0	35	33	35
2025	10	28	18	22	15	25.2	-3.1	1.036	0.4	0.3	0	41.7	31.4	0	132	106	0	35	33	34
2025	10	28	18	32	15	24.9	-1.7	1.035	0.5	0.4	0	42.6	32.3	0	133	107	0	34	32	34
2025	10	28	18	42	15	25.6	-2.7	1.036	0.4	0.3	0	43	31.4	0	134	107	0	34	34	34
2025	10	28	18	52	15	25.6	-2.9	1.036	0.4	0.3	0	43.4	31.8	0	135	108	0	34	34	34
2025	10	28	19	2	15	25.6	-2.5	1.036	0.5	0.4	0	43.4	32.3	0	135	108	0	34	33	34
2025	10	28	19	12	15	25.3	-2.4	1.035	0.4	0.3	0	43.4	32.3	0	136	109	0	35	34	34
2025	10	28	19	22	15	24.7	-3	1.036	0.4	0.3	0	43	31.8	0	135	108	0	35	34	34
2025	10	28	19	32	15	25.7	-3.6	1.036	0.5	0.4	0	43.4	32.7	0	135	109	0	34	33	34
2025	10	28	19	42	15	26	-3.1	1.036	0.3	0.2	0	43.4	32.3	0	135	109	0	34	34	34
2025	10	28	19	52	15	24.3	-3	1.036	0.5	0.4	0	43.4	32.7	0	136	110	0	35	34	35
2025	10	28	20	2	15	23.7	-2.7	1.036	0.5	0.5	0	43.4	32.7	0	136	109	0	35	33	34
2025	10	28	20	12	15	24.1	-2.2	1.037	0.5	0.4	0	43.4	32.7	0	136	109	0	35	33	34
2025	10	28	20	22	15	25.1	-3.3	1.036	0.5	0.5	0	43.4	33.1	0	136	110	0	35	33	34
2025	10	28	20	32	15	24.8	-3.5	1.036	0.5	0.5	0	43.9	32.7	0	136	109	0	34	33	34
2025	10	28	20	42	15	25.5	-2.8	1.037	0.4	0.3	0	43	32.7	0	135	109	0	35	33	35
2025	10	28	20	52	15	25.5	-3.5	1.037	0.4	0.3	0	43.4	33.1	0	136	110	0	35	33	35
2025	10	28	21	2	15	25.1	-2.6	1.037	0.4	0.3	0	43.4	32.3	0	136	109	0	35	34	34
2025	10	28	21	12	15	24.7	-3.3	1.037	0.4	0.3	0	43.4	32.7	0	136	110	0	35	34	34
2025	10	28	21	22	15	25.8	-1.9	1.037	0.5	0.4	0	43.9	33.1	0	136	110	0	34	33	34
2025	10	28	21	32	15	26.1	-2.7	1.038	0.4	0.3	0	43.4	32.7	0	135	109	0	34	33	34
2025	10	28	21	42	15	23.3	-2.9	1.038	0.3	0.2	0	43.9	33.1	0	136	110	0	34	33	34
2025	10	28	21	52	15	26.3	-2.2	1.038	0.5	0.4	0	43.4	32.7	0	136	109	0	35	33	34
2025	10	28	22	2	15	25.8	-3.1	1.037	0.5	0.4	0	43.9	32.7	0	136	110	0	34	34	34
2025	10	28	22	12	15	25.5	-3.1	1.038	0.5	0.4	0	43	32.7	0	135	109	0	35	33	35
2025	10	28	22	22	15	25	-2.6	1.037	0.4	0.3	0	43.4	32.3	0	136	109	0	35	34	35
2025	10	28	22	32	15	25	-2.7	1.038	0.5	0.5	0	43.4	33.1	0	136	110	0	35	33	35
2025	10	28	22	42	15	23.6	-3.2	1.037	0.4	0.3	0	43.9	33.1	0	136	110	0	34	33	34
2025	10	28	22	52	15	24.7	-3	1.037	0.5	0.5	0	43.9	32.3	0	136	109	0	34	34	34
2025	10	28	23	2	15	25.4	-3	1.037	0.3	0.2	0	43	32.7	0	135	109	0	35	33	34
2025	10	28	23	12	15	25.7	-3.1	1.037	0.4	0.3	0	43.9	32.7	0	136	110	0	34	34	34
2025	10	28	23	22	15	26.2	-3.1	1.037	0.3	0.2	0	43	32.3	0	135	109	0	35	34	35
2025	10	28	23	32	15	25	-2.1	1.037	0.5	0.4	0	44.3	33.1	0	137	110	0	34	33	34
2025	10	28	23	42	15	24.9	-2.6	1.037	0.4	0.3	0	43.9	33.1	0	136	110	0	34	33	34
2025	10	28	23	52	15	26.1	-3.5	1.037	0.4	0.3	0	43	32.3	0	135	109	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	29	0	2	15	26.2	-3.7	1.037	0.3	0.2	0	43	31.8	0	135	108	0	35	34	34
2025	10	29	0	12	15	25.4	-2.7	1.037	0.5	0.4	0	43	32.3	0	135	108	0	35	33	35
2025	10	29	0	22	15	25.5	-2.5	1.037	0.4	0.3	0	43.4	32.7	0	135	109	0	34	33	34
2025	10	29	0	32	15	24.5	-2.3	1.037	0.4	0.3	0	43.4	32.7	0	135	109	0	34	33	34
2025	10	29	0	42	15	26.3	-2.8	1.037	0.3	0.2	0	43	33.1	0	135	110	0	35	33	35
2025	10	29	0	52	15	25.2	-2.3	1.037	0.4	0.3	0	43.4	32.7	0	136	110	0	35	34	35
2025	10	29	1	2	15	25.5	-2.8	1.037	0.3	0.2	0	43.4	32.3	0	136	109	0	35	34	34
2025	10	29	1	12	15	24.2	-2.3	1.036	0.3	0.2	0	43.4	32.3	0	135	109	0	34	34	34
2025	10	29	1	22	15	25.7	-3.4	1.037	0.4	0.3	0	43	32.3	0	135	109	0	35	34	34
2025	10	29	1	32	15	25.6	-2.2	1.036	0.3	0.2	0	43	32.7	0	135	109	0	35	33	34
2025	10	29	1	42	15	24.9	-2.4	1.036	0.5	0.4	0	43	31.8	0	135	108	0	35	34	34
2025	10	29	1	52	15	24.9	-2.7	1.036	0.4	0.3	0	43	32.3	0	135	109	0	35	34	35
2025	10	29	2	2	15	25.4	-3	1.036	0.4	0.3	0	43	32.3	0	135	109	0	35	34	34
2025	10	29	2	12	15	25.3	-3	1.036	0.6	0.5	0	43	32.3	0	134	109	0	34	34	34
2025	10	29	2	22	15	24.5	-3	1.036	0.4	0.3	0	43	32.7	0	135	109	0	35	33	34
2025	10	29	2	32	15	25.3	-3.1	1.035	0.5	0.4	0	43	32.7	0	135	109	0	35	33	34
2025	10	29	2	42	15	25	-2.5	1.035	0.5	0.4	0	43	32.7	0	135	109	0	35	33	34
2025	10	29	2	52	15	26	-3.3	1.034	0.5	0.4	0	42.6	32.7	0	134	109	0	35	33	34
2025	10	29	3	2	15	25	-3.8	1.034	0.5	0.4	0	43.4	32.7	0	135	109	0	34	33	34
2025	10	29	3	12	15	24.4	-2.9	1.034	0.5	0.5	0	43	32.3	0	135	109	0	35	34	34
2025	10	29	3	22	15	24.9	-2.2	1.034	0.4	0.3	0	43.4	32.3	0	135	109	0	34	34	34
2025	10	29	3	32	15	23.8	-1.4	1.033	0.4	0.3	0	43	32.7	0	135	109	0	35	33	34
2025	10	29	3	42	15	26.3	-1.8	1.033	0.3	0.2	0	43	32.7	0	135	109	0	35	33	35
2025	10	29	3	52	15	25	-1	1.033	0.4	0.3	0	43	32.3	0	135	109	0	35	34	34
2025	10	29	4	2	15	24.2	-3.3	1.033	0.5	0.4	0	43	32.7	0	134	109	0	34	33	34
2025	10	29	4	12	15	25	-2.1	1.032	0.4	0.3	0	43	32.7	0	135	109	0	35	33	34
2025	10	29	4	22	15	25.1	-3.5	1.032	0.5	0.4	0	42.1	31.8	0	134	108	0	36	34	35
2025	10	29	4	32	15	25.3	-3	1.032	0.3	0.2	0	42.6	31.8	0	134	108	0	35	34	35
2025	10	29	4	42	15	24.2	-3.1	1.032	0.4	0.3	0	42.6	31.8	0	134	108	0	35	34	34
2025	10	29	4	52	15	25.7	-3.2	1.032	0.5	0.4	0	42.6	31.8	0	134	108	0	35	34	34
2025	10	29	5	2	15	25.3	-2.5	1.032	0.4	0.3	0	42.6	32.3	0	134	108	0	35	33	35
2025	10	29	5	12	15	24.7	-3.3	1.032	0.4	0.3	0	33.1	31.8	0	111	108	0	34	34	35
2025	10	29	5	22	15	24.1	-1.9	1.032	0.4	0.3	0	42.6	32.7	0	134	109	0	35	33	34
2025	10	29	5	32	15	25.7	-3.5	1.032	0.4	0.3	0	42.6	31.8	0	134	108	0	35	34	35
2025	10	29	5	42	15	22.9	-1.5	1.032	0.5	0.4	0	43.4	32.3	0	135	109	0	34	34	34
2025	10	29	5	52	15	23.3	-2.2	1.032	0.4	0.3	0	42.6	31.8	0	134	108	0	35	34	34
2025	10	29	6	2	15	25	-2.5	1.032	0.3	0.2	0	42.1	31.8	0	133	108	0	35	34	34
2025	10	29	6	12	15	25.3	-2.7	1.032	0.4	0.3	0	42.6	31.8	0	133	108	0	34	34	34
2025	10	29	6	22	15	25.5	-2.5	1.032	0.4	0.3	0	42.6	31.4	0	133	107	0	34	34	34
2025	10	29	6	32	15	25	-2.5	1.032	0.5	0.4	0	42.1	31.4	0	133	107	0	35	34	34
2025	10	29	6	42	15	25.8	-2	1.032	0.4	0.3	0	42.1	31.4	0	133	107	0	35	34	35
2025	10	29	6	52	15	24.4	-3.5	1.032	0.4	0.3	0	42.6	31.4	0	133	107	0	34	34	34
2025	10	29	7	2	15	24.3	-2.4	1.032	0.3	0.2	0	41.7	31.8	0	132	107	0	35	33	34
2025	10	29	7	12	15	24.8	-3	1.031	0.5	0.5	0	41.7	31	0	132	106	0	35	34	34
2025	10	29	7	22	15	25.7	-2.9	1.031	0.5	0.4	0	42.1	31.4	0	133	106	0	35	33	35
2025	10	29	7	32	15	25.1	-2.4	1.031	0.4	0.3	0	42.1	31.4	0	133	106	0	35	33	34
2025	10	29	7	42	15	25.3	-2.5	1.031	0.5	0.4	0	42.1	30.5	0	132	105	0	34	34	34
2025	10	29	7	52	15	25.5	-3	1.031	0.4	0.3	0	41.3	30.5	0	131	105	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	29	8	2	15	26.3	-2.8	1.031	0.4	0.3	0	41.3	30.5	0	131	105	0	35	34	35
2025	10	29	8	12	15	24.5	-2.1	1.031	0.5	0.4	0	42.1	30.5	0	132	105	0	34	34	34
2025	10	29	8	22	15	24.9	-2.6	1.031	0.5	0.5	0	41.3	31	0	131	105	0	35	33	34
2025	10	29	8	32	15	25.6	-3.2	1.031	0.5	0.4	0	41.7	30.5	0	131	105	0	34	34	34
2025	10	29	8	42	15	26.3	-2.6	1.031	0.5	0.4	0	41.3	31	0	131	105	0	35	33	34
2025	10	29	8	52	15	25	-3.6	1.031	0.5	0.4	0	41.3	30.5	0	131	105	0	35	34	34
2025	10	29	9	2	15	24.8	-3.8	1.031	0.5	0.4	0	41.7	31	0	131	105	0	34	33	34
2025	10	29	9	12	15	25.7	-2.1	1.031	0.5	0.4	0	41.3	30.5	0	130	104	0	34	33	34
2025	10	29	9	22	15	24.9	-2.8	1.031	0.3	0.2	0	41.3	30.1	0	130	104	0	34	34	34
2025	10	29	9	32	15	25.1	-2.7	1.031	0.4	0.3	0	41.3	30.1	0	130	104	0	34	34	35
2025	10	29	9	42	15	24.9	-3	1.032	0.4	0.3	0	40.9	31	0	130	105	0	35	33	34
2025	10	29	9	52	15	25.4	-3	1.032	0.5	0.4	0	40.9	30.1	0	130	104	0	35	34	33
2025	10	29	10	2	15	24.6	-2.1	1.032	0.5	0.4	0	40.9	30.5	0	130	105	0	35	34	34
2025	10	29	10	12	15	25	-2.2	1.032	0.5	0.5	0	40.9	30.5	0	130	105	0	35	34	35
2025	10	29	10	22	15	25	-3.6	1.032	0.5	0.4	0	41.3	30.5	0	131	105	0	35	34	34
2025	10	29	10	32	15	25.7	-3	1.032	0.4	0.3	0	41.3	31	0	131	105	0	35	33	35
2025	10	29	10	42	15	25.4	-3.3	1.032	0.3	0.2	0	42.1	31	0	132	106	0	34	34	34
2025	10	29	10	52	15	25.2	-3.6	1.032	0.5	0.4	0	41.3	31	0	130	105	0	34	33	34
2025	10	29	11	2	15	24.3	-2.4	1.032	0.4	0.3	0	41.7	30.5	0	131	105	0	34	34	34
2025	10	29	11	12	15	24.2	-3	1.032	0.4	0.3	0	40.9	30.5	0	130	104	0	35	33	34
2025	10	29	11	22	15	24.2	-2.1	1.032	0.5	0.4	0	40.4	30.1	0	129	103	0	35	33	35
2025	10	29	11	32	15	24.5	-3	1.032	0.3	0.2	0	40.9	30.1	0	129	103	0	34	33	34
2025	10	29	11	42	15	24.5	-1.9	1.032	0.3	0.2	0	40.9	30.5	0	130	105	0	35	34	34
2025	10	29	11	52	15	24.9	-2.2	1.032	0.4	0.3	0	40.4	30.1	0	129	104	0	35	34	34
2025	10	29	12	2	15	24.8	-2.4	1.032	0.3	0.2	0	40	30.1	0	128	103	0	35	33	34
2025	10	29	12	12	15	24	-1.7	1.032	0.5	0.4	0	40.4	30.1	0	128	103	0	34	33	34
2025	10	29	12	22	15	24.7	-2.2	1.032	0.4	0.3	0	40.4	29.7	0	128	103	0	34	34	34
2025	10	29	12	32	15	24.3	-3.2	1.032	0.4	0.3	0	40	29.2	0	128	102	0	35	34	34
2025	10	29	12	42	15	24.7	-2.9	1.032	0.5	0.5	0	40.4	30.5	0	129	104	0	35	33	34
2025	10	29	12	52	15	26	-3	1.032	0.4	0.3	0	40.4	30.1	0	129	104	0	35	34	34
2025	10	29	13	2	15	24.7	-2.4	1.032	0.5	0.4	0	40.4	30.5	0	129	104	0	35	33	34
2025	10	29	13	12	15	25.2	-3.3	1.032	0.3	0.2	0	41.3	30.5	0	130	105	0	34	34	34
2025	10	29	13	22	15	26.4	-3	1.032	0.4	0.3	0	40.9	29.7	0	129	103	0	34	34	35
2025	10	29	13	32	15	25.4	-4.1	1.032	0.4	0.3	0	41.3	31	0	130	104	0	34	32	34
2025	10	29	13	42	15	24.2	-2.7	1.032	0.5	0.4	0	40.4	30.1	0	129	104	0	35	34	34
2025	10	29	13	52	15	25	-2.6	1.032	0.4	0.3	0	41.3	31	0	130	105	0	34	33	34
2025	10	29	14	2	15	23.9	-3	1.032	0.4	0.3	0	40.4	30.5	0	129	104	0	35	33	34
2025	10	29	14	12	15	25.6	-2.5	1.032	0.4	0.3	0	40.4	30.5	0	129	104	0	35	33	34
2025	10	29	14	22	15	24.4	-2.8	1.032	0.5	0.5	0	40.4	30.1	0	129	104	0	35	34	34
2025	10	29	14	32	15	23.8	-2.6	1.032	0.5	0.4	0	40.4	30.5	0	129	104	0	35	33	34
2025	10	29	14	42	15	24.9	-3.1	1.032	0.4	0.3	0	40.4	30.5	0	129	104	0	35	33	34
2025	10	29	14	52	15	25.8	-3.4	1.032	0.3	0.2	0	40.9	30.5	0	129	104	0	34	33	34
2025	10	29	15	2	15	24.4	-2.2	1.032	0.4	0.3	0	40.9	31	0	130	105	0	35	33	34
2025	10	29	15	12	15	24	-2.9	1.032	0.5	0.5	0	40.4	30.1	0	128	103	0	34	33	35
2025	10	29	15	22	15	23.7	-2.1	1.032	0.5	0.4	0	40.9	30.1	0	129	104	0	34	34	34
2025	10	29	15	32	15	24.1	-1.5	1.032	0.4	0.3	0	40.4	29.7	0	128	103	0	34	34	34
2025	10	29	15	42	15	24.7	-2.7	1.032	0.4	0.3	0	41.3	30.5	0	130	104	0	34	33	34
2025	10	29	15	52	15	26	-3.6	1.031	0.5	0.5	0	41.3	31	0	130	105	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	29	16	2	15	25.5	-3	1.032	0.4	0.3	0	40.9	30.5	0	129	104	0	34	33	34
2025	10	29	16	12	15	25.5	-2.9	1.031	0.5	0.4	0	40.9	30.5	0	130	105	0	35	34	35
2025	10	29	16	22	15	24.2	-2.9	1.031	0.4	0.3	0	42.1	31.4	0	133	107	0	35	34	34
2025	10	29	16	32	15	25.1	-2	1.031	0.4	0.3	0	40.9	31	0	130	105	0	35	33	34
2025	10	29	16	42	15	24.4	-2.5	1.032	0.5	0.5	0	40.9	29.7	0	129	103	0	34	34	34
2025	10	29	16	52	15	26.3	-3	1.031	0.5	0.5	0	40	29.7	0	128	102	0	35	33	34
2025	10	29	17	2	15	25.6	-3	1.031	0.3	0.2	0	40.4	29.2	0	128	102	0	34	34	34
2025	10	29	17	12	15	24.3	-2.9	1.031	0.4	0.3	0	40	29.7	0	128	102	0	35	33	34
2025	10	29	17	22	15	26.2	-3.4	1.031	0.3	0.2	0	40.4	29.2	0	128	102	0	34	34	34
2025	10	29	17	32	15	25.4	-2.6	1.031	0.4	0.3	0	40.9	30.5	0	130	104	0	35	33	34
2025	10	29	17	42	15	24.1	-3.5	1.031	0.4	0.3	0	40.9	30.5	0	130	104	0	35	33	35
2025	10	29	17	52	15	24.3	-2.4	1.031	0.5	0.4	0	40.9	30.5	0	130	104	0	35	33	35
2025	10	29	18	2	15	25.3	-3.4	1.031	0.5	0.5	0	41.3	30.1	0	130	104	0	34	34	34
2025	10	29	18	12	15	25	-2.7	1.031	0.4	0.3	0	41.3	30.5	0	131	105	0	35	34	34
2025	10	29	18	22	15	25.4	-2.7	1.031	0.4	0.3	0	41.7	30.5	0	131	105	0	34	34	35
2025	10	29	18	32	15	26.3	-2.5	1.031	0.4	0.3	0	41.7	30.5	0	131	105	0	34	34	35
2025	10	29	18	42	15	26	-3.3	1.031	0.3	0.2	0	41.7	31	0	132	106	0	35	34	35
2025	10	29	18	52	15	25.4	-2.7	1.031	0.3	0.2	0	42.6	31.4	0	133	107	0	34	34	35
2025	10	29	19	2	15	25.4	-2.7	1.031	0.4	0.3	0	43	32.3	0	134	108	0	34	33	34
2025	10	29	19	12	15	24.9	-2.5	1.031	0.5	0.4	0	42.6	32.3	0	134	108	0	35	33	34
2025	10	29	19	22	15	25.3	-2.4	1.031	0.4	0.3	0	42.6	32.3	0	134	108	0	35	33	35
2025	10	29	19	32	15	24.7	-2.6	1.031	0.4	0.3	0	42.6	32.3	0	134	108	0	35	33	34
2025	10	29	19	42	15	25	-3.3	1.031	0.4	0.3	0	43	31.8	0	135	108	0	35	34	34
2025	10	29	19	52	15	25.8	-2.1	1.031	0.5	0.4	0	43	31.8	0	134	108	0	34	34	34
2025	10	29	20	2	15	24.4	-2.1	1.031	0.4	0.3	0	43.4	32.3	0	135	109	0	34	34	34
2025	10	29	20	12	15	24.9	-3.9	1.031	0.4	0.3	0	43	32.3	0	134	109	0	34	34	34
2025	10	29	20	22	15	25.8	-2.6	1.031	0.4	0.3	0	43	32.7	0	135	109	0	35	33	34
2025	10	29	20	32	15	25.6	-3	1.031	0.3	0.2	0	43	32.7	0	135	109	0	35	33	34
2025	10	29	20	42	15	23.4	-3	1.031	0.3	0.2	0	43.4	32.7	0	135	109	0	34	33	34
2025	10	29	20	52	15	23.6	-1.7	1.031	0.4	0.3	0	43.4	32.7	0	135	109	0	34	33	34
2025	10	29	21	2	15	24.6	-3	1.031	0.5	0.4	0	43	33.1	0	135	110	0	35	33	34
2025	10	29	21	12	15	25	-2.1	1.031	0.5	0.4	0	42.6	32.3	0	134	108	0	35	33	34
2025	10	29	21	22	15	24.5	-2.9	1.031	0.3	0.2	0	43.4	32.3	0	135	109	0	34	34	35
2025	10	29	21	32	15	24.8	-3.3	1.031	0.3	0.2	0	43.4	32.3	0	135	109	0	34	34	34
2025	10	29	21	42	15	23.6	-3.5	1.031	0.5	0.4	0	43	32.7	0	134	109	0	34	33	34
2025	10	29	21	52	15	24.4	-3	1.031	0.5	0.4	0	43	33.1	0	135	110	0	35	33	34
2025	10	29	22	2	15	25.4	-2.7	1.031	0.5	0.4	0	43	32.7	0	135	109	0	35	33	34
2025	10	29	22	12	15	24.1	-1.9	1.031	0.5	0.5	0	43.4	33.1	0	135	110	0	34	33	34
2025	10	29	22	22	15	24.8	-3	1.031	0.4	0.3	0	42.6	31.8	0	134	108	0	35	34	35
2025	10	29	22	32	15	24.5	-2.1	1.031	0.4	0.3	0	42.6	32.3	0	134	109	0	35	34	34
2025	10	29	22	42	15	26.3	-3	1.031	0.5	0.5	0	42.6	31.8	0	134	108	0	35	34	35
2025	10	29	22	52	15	24.8	-2.6	1.031	0.4	0.3	0	43	32.3	0	135	109	0	35	34	34
2025	10	29	23	2	15	24.4	-3	1.032	0.4	0.3	0	42.6	32.3	0	134	109	0	35	34	34
2025	10	29	23	12	15	24.7	-3	1.031	0.5	0.4	0	41.7	32.3	0	132	109	0	35	34	35
2025	10	29	23	22	15	25.8	-1.8	1.031	0.5	0.4	0	42.6	31.8	0	134	108	0	35	34	35
2025	10	29	23	32	15	23.9	-2.4	1.032	0.5	0.4	0	43.4	32.3	0	135	109	0	34	34	34
2025	10	29	23	42	15	24.7	-2.6	1.031	0.3	0.2	0	43	32.3	0	134	109	0	34	34	34
2025	10	29	23	52	15	24.8	-1.8	1.031	0.4	0.3	0	42.6	32.3	0	134	109	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	30	0	2	15	26	-3	1.031	0.4	0.3	0	42.6	32.3	0	134	109	0	35	34	34
2025	10	30	0	12	15	24	-2.6	1.031	0.4	0.3	0	42.6	32.3	0	134	109	0	35	34	34
2025	10	30	0	22	15	24.5	-3.4	1.031	0.5	0.4	0	43	32.3	0	134	109	0	34	34	35
2025	10	30	0	32	15	26	-2.6	1.031	0.5	0.4	0	42.6	32.7	0	134	109	0	35	33	34
2025	10	30	0	42	15	25.3	-2.8	1.031	0.5	0.4	0	43	32.3	0	134	108	0	34	33	34
2025	10	30	0	52	15	24.5	-3.3	1.032	0.3	0.2	0	43	31.8	0	135	108	0	35	34	34
2025	10	30	1	2	15	26.4	-2.7	1.031	0.4	0.3	0	42.6	31.8	0	134	108	0	35	34	35
2025	10	30	1	12	15	24.7	-3.5	1.031	0.4	0.3	0	43	32.3	0	134	108	0	34	33	34
2025	10	30	1	22	15	25.1	-3.3	1.031	0.3	0.2	0	43	31.8	0	134	108	0	34	34	35
2025	10	30	1	32	15	25.6	-3	1.032	0.5	0.4	0	42.6	31.8	0	134	108	0	35	34	35
2025	10	30	1	42	15	25.4	-3.7	1.031	0.4	0.3	0	43	31.8	0	134	108	0	34	34	34
2025	10	30	1	52	15	25.9	-2.5	1.031	0.4	0.3	0	42.6	32.3	0	134	108	0	35	33	35
2025	10	30	2	2	15	24.7	-2.3	1.031	0.4	0.3	0	43	31.8	0	134	108	0	34	34	34
2025	10	30	2	12	15	25.4	-3.2	1.031	0.3	0.2	0	42.6	31.8	0	134	108	0	35	34	35
2025	10	30	2	22	15	25.1	-1.7	1.032	0.4	0.3	0	43.4	32.7	0	135	109	0	34	33	34
2025	10	30	2	32	15	24.5	-2.9	1.031	0.5	0.5	0	42.1	32.3	0	133	108	0	35	33	35
2025	10	30	2	42	15	25.7	-2.9	1.031	0.4	0.3	0	42.1	31.4	0	133	107	0	35	34	35
2025	10	30	2	52	15	23.8	-3.2	1.031	0.4	0.3	0	42.6	32.3	0	134	108	0	35	33	35
2025	10	30	3	2	15	25.1	-3.8	1.031	0.5	0.4	0	42.1	32.3	0	133	108	0	35	33	35
2025	10	30	3	12	15	24.4	-1.9	1.032	0.4	0.3	0	42.1	31.8	0	133	108	0	35	34	34
2025	10	30	3	22	15	25.1	-2.6	1.031	0.3	0.2	0	42.1	31.4	0	133	107	0	35	34	34
2025	10	30	3	32	15	24.6	-2.1	1.032	0.5	0.4	0	42.1	31.8	0	133	107	0	35	33	35
2025	10	30	3	42	15	24.9	-3.2	1.032	0.3	0.2	0	42.1	31.4	0	132	107	0	34	34	35
2025	10	30	3	52	15	25.2	-3.7	1.032	0.4	0.3	0	42.1	31.8	0	132	107	0	34	33	34
2025	10	30	4	2	15	24.4	-2.4	1.032	0.5	0.4	0	41.7	30.5	0	132	105	0	35	34	34
2025	10	30	4	12	15	25.5	-3.3	1.032	0.3	0.2	0	42.1	31.8	0	133	108	0	35	34	35
2025	10	30	4	22	15	25	-2.9	1.032	0.4	0.3	0	41.7	31.4	0	132	107	0	35	34	34
2025	10	30	4	32	15	25.4	-3.4	1.032	0.4	0.3	0	42.6	31.4	0	134	107	0	35	34	35
2025	10	30	4	42	15	25.8	-3.1	1.033	0.5	0.4	0	42.1	31.8	0	133	107	0	35	33	34
2025	10	30	4	52	15	25.2	-4	1.032	0.4	0.3	0	42.1	31	0	133	106	0	35	34	34
2025	10	30	5	2	15	24.5	-3.1	1.032	0.4	0.3	0	42.6	31.4	0	133	107	0	34	34	34
2025	10	30	5	12	15	24.4	-3	1.033	0.5	0.5	0	42.6	31.4	0	134	107	0	35	34	35
2025	10	30	5	22	15	23.8	-2.9	1.032	0.3	0.2	0	42.1	31.4	0	133	107	0	35	34	35
2025	10	30	5	32	15	24.8	-3.4	1.032	0.4	0.3	0	41.7	31.8	0	132	107	0	35	33	34
2025	10	30	5	42	15	24.3	-2.3	1.032	0.5	0.4	0	42.1	31.4	0	133	107	0	35	34	34
2025	10	30	5	52	15	25.1	-2.9	1.033	0.4	0.3	0	42.1	31.4	0	133	107	0	35	34	34
2025	10	30	6	2	15	24.3	-3.5	1.032	0.4	0.3	0	48.6	37.4	0	148	121	0	35	34	35
2025	10	30	6	12	15	25.5	-2.6	1.033	0.5	0.5	0	46.4	36.1	0	143	117	0	35	33	34
2025	10	30	6	22	15	25.3	-3.3	1.033	0.4	0.3	0	43.9	32.7	0	136	109	0	34	33	34
2025	10	30	6	32	15	23.5	-3	1.033	0.4	0.3	0	43	32.3	0	134	108	0	34	33	35
2025	10	30	6	42	15	26	-3.9	1.033	0.5	0.4	0	42.1	31	0	132	106	0	34	34	34
2025	10	30	6	52	15	24.3	-2.4	1.033	0.4	0.3	0	41.7	31.4	0	132	106	0	35	33	34
2025	10	30	7	2	15	25.7	-2.4	1.034	0.3	0.2	0	41.7	31	0	132	106	0	35	34	34
2025	10	30	7	12	15	25.5	-2.5	1.033	0.3	0.2	0	41.3	30.5	0	131	105	0	35	34	35
2025	10	30	7	22	15	25.6	-3.1	1.033	0.4	0.3	0	41.7	30.5	0	131	105	0	34	34	34
2025	10	30	7	32	15	25.1	-4.2	1.033	0.5	0.5	0	41.3	30.5	0	131	105	0	35	34	34
2025	10	30	7	42	15	24.9	-2.7	1.033	0.5	0.4	0	41.3	30.1	0	130	104	0	34	34	34
2025	10	30	7	52	15	26	-2.6	1.034	0.5	0.4	0	40.9	30.5	0	130	104	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	30	8	2	15	23.9	-3	1.033	0.3	0.2	0	40.4	30.1	0	129	104	0	35	34	34
2025	10	30	8	12	15	24.9	-3	1.035	0.4	0.3	0	41.3	30.1	0	130	104	0	34	34	35
2025	10	30	8	22	15	26.5	-3	1.034	0.4	0.3	0	41.3	30.1	0	130	104	0	34	34	35
2025	10	30	8	32	15	22.8	-1.7	1.034	0.5	0.5	0	40.4	30.1	0	129	103	0	35	33	35
2025	10	30	8	42	15	24.8	-2.6	1.035	0.3	0.2	0	40.4	30.1	0	128	103	0	34	33	34
2025	10	30	8	52	15	25.4	-1.9	1.034	0.4	0.3	0	40	30.1	0	128	103	0	35	33	35
2025	10	30	9	2	15	25	-3.1	1.033	0.4	0.3	0	40.4	29.2	0	128	102	0	34	34	35
2025	10	30	9	12	15	26.2	-2.5	1.034	0.3	0.2	0	40	29.2	0	127	102	0	34	34	35
2025	10	30	9	22	15	25.8	-3	1.034	0.4	0.3	0	40	29.2	0	127	102	0	34	34	34
2025	10	30	9	32	15	25.3	-3	1.033	0.5	0.5	0	40.4	29.2	0	128	102	0	34	34	35
2025	10	30	9	42	15	25.7	-3	1.034	0.4	0.3	0	40.4	30.1	0	128	103	0	34	33	35
2025	10	30	9	52	15	24.7	-3.1	1.034	0.3	0.2	0	40.4	30.1	0	128	103	0	34	33	34
2025	10	30	10	2	15	23.6	-2.4	1.034	0.4	0.3	0	38.7	29.2	0	125	101	0	35	33	34
2025	10	30	10	12	15	25.6	-2.5	1.034	0.5	0.5	0	38.7	28.8	0	125	101	0	35	34	35
2025	10	30	10	22	15	25.2	-2.8	1.034	0.5	0.4	0	39.6	29.2	0	127	102	0	35	34	34
2025	10	30	10	32	15	26	-3.8	1.035	0.5	0.5	0	38.7	28.4	0	125	100	0	35	34	35
2025	10	30	10	42	15	25.2	-2.1	1.036	0.3	0.2	0	39.1	28.4	0	125	100	0	34	34	35
2025	10	30	10	52	15	25.9	-3.7	1.036	0.4	0.3	0	38.7	28	0	124	99	0	34	34	35
2025	10	30	11	2	15	25.4	-3.5	1.035	0.5	0.4	0	38.7	28	0	125	99	0	35	34	34
2025	10	30	11	12	15	23.8	-3	1.035	0.5	0.4	0	38.7	28.4	0	125	100	0	35	34	35
2025	10	30	11	22	15	25.5	-2.8	1.036	0.5	0.4	0	38.7	28.8	0	125	100	0	35	33	35
2025	10	30	11	32	15	25.1	-3.2	1.036	0.4	0.3	0	38.7	28.4	0	125	100	0	35	34	34
2025	10	30	11	42	15	25.4	-2.6	1.035	0.4	0.3	0	38.3	28	0	124	99	0	35	34	34
2025	10	30	11	52	15	25.5	-3	1.035	0.5	0.4	0	38.3	28	0	124	99	0	35	34	34
2025	10	30	12	2	15	25.6	-3.2	1.036	0.3	0.2	0	39.1	28.4	0	125	100	0	34	34	35
2025	10	30	12	12	15	24.8	-3.5	1.035	0.4	0.3	0	38.7	28.4	0	125	100	0	35	34	34
2025	10	30	12	22	15	25.4	-3.3	1.035	0.5	0.4	0	38.7	28.4	0	124	99	0	34	33	34
2025	10	30	12	32	15	25.2	-2.8	1.036	0.3	0.2	0	38.7	28.8	0	125	100	0	35	33	34
2025	10	30	12	42	15	24	-3.9	1.035	0.5	0.4	0	39.1	28.8	0	125	100	0	34	33	34
2025	10	30	12	52	15	25.9	-4	1.035	0.5	0.4	0	38.7	29.2	0	125	100	0	35	32	34
2025	10	30	13	2	15	25.4	-1.5	1.035	0.4	0.3	0	39.1	28.8	0	126	100	0	35	33	35
2025	10	30	13	12	15	24.2	-2.4	1.035	0.5	0.5	0	39.1	28.4	0	125	100	0	34	34	34
2025	10	30	13	22	15	25.5	-3.5	1.035	0.5	0.4	0	39.1	28.8	0	126	101	0	35	34	35
2025	10	30	13	32	15	24.7	-3.1	1.035	0.5	0.4	0	39.1	28.4	0	125	100	0	34	34	34
2025	10	30	13	42	15	25.6	-3	1.034	0.4	0.3	0	39.1	28.8	0	126	101	0	35	34	34
2025	10	30	13	52	15	25.3	-3.8	1.035	0.4	0.3	0	39.1	29.2	0	126	101	0	35	33	34
2025	10	30	14	2	15	25.8	-3.4	1.034	0.3	0.2	0	39.1	28.8	0	126	101	0	35	34	34
2025	10	30	14	12	15	24.3	-2.7	1.034	0.5	0.5	0	38.7	28.8	0	125	101	0	35	34	34
2025	10	30	14	22	15	25.5	-2.8	1.034	0.5	0.4	0	38.7	29.2	0	125	101	0	35	33	34
2025	10	30	14	32	15	23.4	-2.2	1.035	0.4	0.3	0	39.1	28.8	0	125	101	0	34	34	34
2025	10	30	14	42	15	24.6	-2.2	1.034	0.4	0.3	0	38.7	29.2	0	125	101	0	35	33	34
2025	10	30	14	52	15	22.9	-3	1.034	0.4	0.3	0	39.1	28.8	0	125	100	0	34	33	35
2025	10	30	15	2	15	24.6	-3.1	1.035	0.3	0.2	0	38.7	29.2	0	125	101	0	35	33	34
2025	10	30	15	12	15	24.2	-1.8	1.034	0.5	0.4	0	38.7	29.2	0	125	101	0	35	33	34
2025	10	30	15	22	15	24.6	-2.3	1.034	0.4	0.3	0	39.1	29.2	0	126	101	0	35	33	35
2025	10	30	15	32	15	25	-2.1	1.034	0.3	0.2	0	39.1	29.2	0	126	101	0	35	33	34
2025	10	30	15	42	15	25	-2.2	1.034	0.5	0.4	0	39.1	29.2	0	126	102	0	35	34	34
2025	10	30	15	52	15	24.3	-2.9	1.034	0.5	0.4	0	39.1	29.2	0	126	101	0	35	33	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	30	16	2	15	25.1	-3.5	1.034	0.4	0.3	0	39.1	29.2	0	125	101	0	34	33	34
2025	10	30	16	12	15	25	-2.6	1.033	0.3	0.2	0	39.1	29.2	0	126	101	0	35	33	35
2025	10	30	16	22	15	24.8	-3.7	1.033	0.5	0.4	0	39.6	29.2	0	126	101	0	34	33	34
2025	10	30	16	32	15	24.8	-2.2	1.033	0.5	0.4	0	39.1	28.8	0	125	100	0	34	33	34
2025	10	30	16	42	15	25.4	-3.2	1.033	0.5	0.4	0	38.7	28.8	0	125	100	0	35	33	35
2025	10	30	16	52	15	25.4	-3.4	1.033	0.3	0.2	0	39.1	28.8	0	126	100	0	35	33	34
2025	10	30	17	2	15	25.7	-3.3	1.033	0.4	0.3	0	39.1	28.4	0	126	100	0	35	34	35
2025	10	30	17	12	15	24.2	-2.8	1.033	0.4	0.3	0	39.1	28.8	0	126	100	0	35	33	34
2025	10	30	17	22	15	25	-2.3	1.033	0.3	0.2	0	39.1	28	0	125	99	0	34	34	35
2025	10	30	17	32	15	26.7	-3	1.034	0.4	0.3	0	40.4	29.7	0	128	102	0	34	33	34
2025	10	30	17	42	15	24.9	-3.1	1.033	0.4	0.3	0	39.6	28.8	0	127	101	0	35	34	35
2025	10	30	17	52	15	25.5	-3.3	1.034	0.4	0.3	0	40.4	29.7	0	128	102	0	34	33	34
2025	10	30	18	2	15	25.1	-3	1.034	0.3	0.2	0	39.6	28.8	0	126	101	0	34	34	34
2025	10	30	18	12	15	25.5	-3.3	1.033	0.4	0.3	0	40	28.8	0	127	101	0	34	34	34
2025	10	30	18	22	15	24.9	-4.8	1.033	0.5	0.4	0	39.6	29.2	0	127	102	0	35	34	35
2025	10	30	18	32	15	25.8	-2.5	1.033	0.5	0.5	0	41.3	30.5	0	130	104	0	34	33	34
2025	10	30	18	42	15	25.1	-3.7	1.034	0.5	0.4	0	41.3	30.1	0	130	104	0	34	34	34
2025	10	30	18	52	15	25.6	-3.2	1.034	0.3	0.2	0	41.7	31	0	131	105	0	34	33	34
2025	10	30	19	2	15	25.9	-3.2	1.034	0.4	0.3	0	41.3	30.5	0	131	105	0	35	34	35
2025	10	30	19	12	15	26.2	-3	1.034	0.5	0.4	0	41.7	31	0	131	105	0	34	33	35
2025	10	30	19	22	15	24.9	-1.9	1.034	0.5	0.4	0	42.1	31.4	0	132	106	0	34	33	34
2025	10	30	19	32	15	26.4	-2.7	1.034	0.3	0.2	0	41.7	31	0	131	105	0	34	33	35
2025	10	30	19	42	15	24.1	-3.5	1.034	0.5	0.5	0	41.7	30.5	0	131	105	0	34	34	34
2025	10	30	19	52	15	24.1	-2.7	1.035	0.5	0.4	0	42.1	32.3	0	133	108	0	35	33	34
2025	10	30	20	2	15	24.6	-3	1.035	0.4	0.3	0	41.7	31.4	0	132	107	0	35	34	34
2025	10	30	20	12	15	24	-2.5	1.034	0.5	0.4	0	43	31.8	0	134	108	0	34	34	34
2025	10	30	20	22	15	24.6	-2.4	1.035	0.5	0.4	0	41.7	31.4	0	132	107	0	35	34	34
2025	10	30	20	32	15	24.4	-2.8	1.036	0.5	0.4	0	42.6	31.8	0	133	107	0	34	33	36
2025	10	30	20	42	15	25.8	-2.6	1.036	0.4	0.3	0	41.7	31.4	0	132	107	0	35	34	34
2025	10	30	20	52	15	25.1	-2.7	1.036	0.5	0.5	0	41.7	31.8	0	132	107	0	35	33	35
2025	10	30	21	2	15	24.7	-2.1	1.036	0.5	0.4	0	42.1	31.8	0	133	108	0	35	34	34
2025	10	30	21	12	15	25.1	-3.2	1.036	0.4	0.3	0	41.7	31.8	0	132	107	0	35	33	35
2025	10	30	21	22	15	25.4	-3	1.036	0.3	0.2	0	42.1	31.8	0	133	107	0	35	33	34
2025	10	30	21	32	15	24.7	-2.3	1.036	0.5	0.4	0	41.7	31	0	132	106	0	35	34	34
2025	10	30	21	42	15	23.9	-2.7	1.036	0.5	0.5	0	41.7	31.8	0	132	107	0	35	33	34
2025	10	30	21	52	15	25.9	-3.2	1.036	0.4	0.3	0	41.7	31	0	132	106	0	35	34	34
2025	10	30	22	2	15	23.9	-3.3	1.036	0.6	0.5	0	42.1	31.4	0	132	106	0	34	33	35
2025	10	30	22	12	15	25.1	-2.5	1.036	0.5	0.4	0	42.1	31.8	0	132	107	0	34	33	35
2025	10	30	22	22	15	25.1	-3	1.037	0.4	0.3	0	41.7	31	0	132	106	0	35	34	35
2025	10	30	22	32	15	24.7	-2.8	1.037	0.4	0.3	0	41.7	31	0	131	106	0	34	34	34
2025	10	30	22	42	15	25.5	-2.1	1.036	0.5	0.4	0	41.3	30.5	0	131	106	0	35	35	34
2025	10	30	22	52	15	23.7	-2.6	1.036	0.4	0.3	0	41.3	31	0	131	106	0	35	34	35
2025	10	30	23	2	15	25.1	-2.2	1.036	0.5	0.4	0	41.7	31.4	0	132	106	0	35	33	35
2025	10	30	23	12	15	24.7	-2.9	1.037	0.3	0.2	0	41.3	31	0	131	106	0	35	34	35
2025	10	30	23	22	15	25.9	-2.4	1.037	0.3	0.2	0	41.3	30.5	0	131	105	0	35	34	34
2025	10	30	23	32	15	25.1	-3.2	1.036	0.3	0.2	0	41.7	31.4	0	132	107	0	35	34	34
2025	10	30	23	42	15	23.8	-2.1	1.037	0.4	0.3	0	41.7	31.4	0	132	107	0	35	34	34
2025	10	30	23	52	15	25	-3.4	1.037	0.4	0.3	0	41.3	31.4	0	131	106	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	31	0	2	15	24.5	-3.9	1.037	0.3	0.2	0	41.3	31.4	0	131	106	0	35	33	34
2025	10	31	0	12	15	24	-2.9	1.037	0.4	0.3	0	41.3	31	0	131	106	0	35	34	35
2025	10	31	0	22	15	25.3	-3.1	1.037	0.5	0.5	0	41.3	30.5	0	131	105	0	35	34	34
2025	10	31	0	32	15	25.2	-2.7	1.037	0.5	0.4	0	41.7	31.4	0	132	106	0	35	33	34
2025	10	31	0	42	15	25.4	-3.2	1.037	0.3	0.2	0	41.3	30.5	0	130	104	0	34	33	35
2025	10	31	0	52	15	24.2	-3.6	1.037	0.4	0.3	0	41.3	30.5	0	131	105	0	35	34	34
2025	10	31	1	2	15	25.8	-2.9	1.037	0.5	0.4	0	40.9	30.5	0	130	105	0	35	34	35
2025	10	31	1	12	15	23.5	-4.3	1.037	0.5	0.4	0	41.7	31	0	131	106	0	34	34	35
2025	10	31	1	22	15	25.2	-3	1.037	0.4	0.3	0	41.3	31	0	131	105	0	35	33	34
2025	10	31	1	32	15	25.1	-2.8	1.037	0.3	0.2	0	43.4	33.5	0	136	111	0	35	33	34
2025	10	31	1	42	15	24.1	-2.9	1.037	0.4	0.3	0	41.3	31.4	0	131	106	0	35	33	34
2025	10	31	1	52	15	24.9	-4.2	1.037	0.4	0.3	0	41.3	31	0	131	106	0	35	34	35
2025	10	31	2	2	15	23.5	-3	1.037	0.3	0.2	0	41.3	31.4	0	131	106	0	35	33	35
2025	10	31	2	12	15	24.9	-2.2	1.037	0.3	0.2	0	41.3	30.5	0	130	105	0	34	34	34
2025	10	31	2	22	15	24.9	-2.9	1.037	0.4	0.3	0	41.7	30.5	0	131	105	0	34	34	35
2025	10	31	2	32	15	25.5	-3.1	1.037	0.3	0.2	0	41.3	31	0	131	106	0	35	34	35
2025	10	31	2	42	15	26.3	-3.8	1.037	0.5	0.5	0	40.9	30.5	0	130	105	0	35	34	34
2025	10	31	2	52	15	25.6	-2.8	1.037	0.4	0.3	0	40.9	31	0	130	105	0	35	33	34
2025	10	31	3	2	15	25.4	-2.5	1.037	0.5	0.4	0	41.3	31.8	0	131	107	0	35	33	34
2025	10	31	3	12	15	25.9	-3.1	1.037	0.3	0.2	0	41.3	31.8	0	131	107	0	35	33	35
2025	10	31	3	22	15	25.1	-1.6	1.037	0.4	0.3	0	40.9	31	0	130	106	0	35	34	34
2025	10	31	3	32	15	25	-2.5	1.037	0.5	0.4	0	41.3	31.4	0	131	107	0	35	34	34
2025	10	31	3	42	15	26.3	-2.6	1.037	0.4	0.3	0	40.9	31	0	130	106	0	35	34	35
2025	10	31	3	52	15	25.3	-2.3	1.037	0.4	0.3	0	41.3	31.4	0	131	106	0	35	33	34
2025	10	31	4	2	15	25.1	-3.8	1.037	0.3	0.2	0	40.9	30.5	0	130	106	0	35	35	35
2025	10	31	4	12	15	23.8	-1.8	1.037	0.4	0.3	0	41.3	30.1	0	131	103	0	35	33	34
2025	10	31	4	22	15	26.5	-3.2	1.037	0.5	0.4	0	40.9	31.4	0	130	106	0	35	33	35
2025	10	31	4	32	15	24.3	-2.4	1.037	0.4	0.3	0	40.9	31.4	0	130	107	0	35	34	34
2025	10	31	4	42	15	25.7	-2.7	1.037	0.5	0.4	0	41.3	31	0	130	106	0	34	34	35
2025	10	31	4	52	15	25	-2.9	1.037	0.5	0.4	0	40.9	31	0	130	106	0	35	34	34
2025	10	31	5	2	15	25.5	-3.5	1.037	0.5	0.5	0	44.3	34.8	0	138	114	0	35	33	34
2025	10	31	5	12	15	26	-2.2	1.037	0.5	0.5	0	40.9	31	0	130	106	0	35	34	35
2025	10	31	5	22	15	25.1	-2.3	1.037	0.5	0.4	0	41.3	31	0	130	106	0	34	34	35
2025	10	31	5	32	15	25.8	-2.3	1.037	0.4	0.3	0	40.9	31	0	130	106	0	35	34	34
2025	10	31	5	42	15	25.1	-2.5	1.037	0.3	0.2	0	40.9	31	0	130	106	0	35	34	35
2025	10	31	5	52	15	25.9	-4.1	1.037	0.4	0.3	0	40.4	30.5	0	129	105	0	35	34	34
2025	10	31	6	2	15	25.1	-3.4	1.038	0.4	0.3	0	40.4	30.5	0	129	105	0	35	34	34
2025	10	31	6	12	15	25.5	-2.9	1.037	0.4	0.3	0	40	30.5	0	128	105	0	35	34	34
2025	10	31	6	22	15	25.8	-3.3	1.037	0.4	0.3	0	40.4	30.5	0	129	105	0	35	34	34
2025	10	31	6	32	15	25	-2.8	1.038	0.4	0.3	0	40.4	30.5	0	128	105	0	34	34	34
2025	10	31	6	42	15	25.1	-2.3	1.037	0.3	0.2	0	40	30.5	0	128	105	0	35	34	34
2025	10	31	6	52	15	24.8	-2.3	1.038	0.4	0.3	0	40	30.5	0	128	104	0	35	33	34
2025	10	31	7	2	15	25.2	-2.4	1.038	0.4	0.3	0	39.6	30.1	0	127	103	0	35	33	34
2025	10	31	7	12	15	25.1	-2.9	1.038	0.4	0.3	0	39.6	30.1	0	127	104	0	35	34	35
2025	10	31	7	22	15	24.3	-2.9	1.038	0.3	0.2	0	39.1	29.7	0	126	103	0	35	34	34
2025	10	31	7	32	15	25.1	-3.2	1.038	0.5	0.4	0	39.1	29.7	0	127	103	0	36	34	35
2025	10	31	7	42	15	24.1	-2.7	1.038	0.4	0.3	0	40.4	30.5	0	129	105	0	35	34	34
2025	10	31	7	52	15	25.4	-2.5	1.038	0.4	0.3	0	39.1	29.2	0	126	102	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	31	8	2	15	25.1	-2.7	1.038	0.5	0.4	0	39.1	29.7	0	126	103	0	35	34	34
2025	10	31	8	12	15	24.9	-2.4	1.038	0.4	0.3	0	38.7	30.1	0	125	103	0	35	33	34
2025	10	31	8	22	15	24.4	-2.9	1.038	0.4	0.3	0	39.1	29.7	0	126	103	0	35	34	34
2025	10	31	8	32	15	25.1	-2.9	1.038	0.5	0.4	0	38.7	29.7	0	125	103	0	35	34	34
2025	10	31	8	42	15	26.6	-3.3	1.038	0.4	0.3	0	39.6	30.1	0	127	104	0	35	34	35
2025	10	31	8	52	15	23.4	-3.2	1.038	0.3	0.2	0	39.1	30.1	0	126	103	0	35	33	34
2025	10	31	9	2	15	25.2	-2.6	1.038	0.4	0.3	0	39.1	29.7	0	126	103	0	35	34	34
2025	10	31	9	12	15	24.8	-2.7	1.038	0.5	0.4	0	38.7	29.7	0	125	102	0	35	33	34
2025	10	31	9	22	15	24.9	-2.2	1.038	0.3	0.2	0	38.7	29.2	0	125	102	0	35	34	34
2025	10	31	9	32	15	24.5	-2.8	1.038	0.5	0.4	0	39.1	29.2	0	125	102	0	34	34	34
2025	10	31	9	42	15	25.2	-3.2	1.038	0.3	0.2	0	38.3	29.2	0	124	101	0	35	33	35
2025	10	31	9	52	15	26.2	-3.3	1.038	0.4	0.3	0	37.8	28.8	0	123	100	0	35	33	34
2025	10	31	10	2	15	25.3	-3	1.038	0.5	0.4	0	38.3	28.8	0	123	100	0	34	33	34
2025	10	31	10	12	15	24.4	-2	1.038	0.4	0.3	0	39.1	29.7	0	126	103	0	35	34	34
2025	10	31	10	22	15	25	-2.3	1.038	0.4	0.3	0	39.6	29.7	0	126	103	0	34	34	35
2025	10	31	10	32	15	26.2	-4.2	1.038	0.5	0.5	0	38.7	29.7	0	125	102	0	35	33	35
2025	10	31	10	42	15	26.1	-3.8	1.038	0.5	0.4	0	38.3	29.2	0	124	101	0	35	33	34
2025	10	31	10	52	15	24	-3.1	1.038	0.5	0.4	0	38.7	28.8	0	125	101	0	35	34	34
2025	10	31	11	2	15	24.4	-2.5	1.038	0.4	0.3	0	38.7	29.2	0	125	102	0	35	34	34
2025	10	31	11	12	15	25.5	-3	1.038	0.3	0.2	0	38.7	28.8	0	124	101	0	34	34	35
2025	10	31	11	22	15	25	-2.1	1.038	0.5	0.4	0	37.8	29.2	0	123	101	0	35	33	34
2025	10	31	11	32	15	26	-2.5	1.038	0.4	0.3	0	38.3	28.8	0	124	101	0	35	34	34
2025	10	31	11	42	15	24.1	-3	1.038	0.5	0.4	0	38.3	29.2	0	124	101	0	35	33	33
2025	10	31	11	52	15	25.5	-3.1	1.038	0.4	0.3	0	38.3	28.8	0	123	100	0	34	33	35
2025	10	31	12	2	15	25.5	-3.6	1.038	0.4	0.3	0	37.8	29.2	0	123	101	0	35	33	34
2025	10	31	12	12	15	25.3	-3	1.038	0.3	0.2	0	37.8	28.4	0	123	100	0	35	34	35
2025	10	31	12	22	15	25.1	-3.2	1.038	0.4	0.3	0	37.8	28.4	0	123	100	0	35	34	34
2025	10	31	12	32	15	25.6	-4	1.038	0.4	0.3	0	37.4	28.4	0	122	100	0	35	34	34
2025	10	31	12	42	15	25.8	-2.9	1.038	0.5	0.4	0	37.4	28.8	0	122	100	0	35	33	35
2025	10	31	12	52	15	25.9	-3.9	1.038	0.4	0.3	0	37.8	28.8	0	123	100	0	35	33	34
2025	10	31	13	2	15	24.7	-3	1.038	0.4	0.3	0	37.8	28	0	122	99	0	34	34	34
2025	10	31	13	12	15	24.3	-3.2	1.037	0.4	0.3	0	37	28.4	0	122	100	0	36	34	34
2025	10	31	13	22	15	25.6	-2.9	1.037	0.5	0.4	0	37.4	28	0	122	99	0	35	34	35
2025	10	31	13	32	15	23.6	-3.6	1.037	0.4	0.3	0	37.4	28.4	0	122	100	0	35	34	35
2025	10	31	13	42	15	24.2	-3.5	1.037	0.3	0.2	0	37.8	28.8	0	123	100	0	35	33	34
2025	10	31	13	52	15	25.2	-3.9	1.036	0.3	0.2	0	37.8	28.4	0	122	99	0	34	33	34
2025	10	31	14	2	15	24.8	-2.7	1.036	0.4	0.3	0	37.4	28.8	0	122	100	0	35	33	34
2025	10	31	14	12	15	24.6	-2.7	1.035	0.4	0.3	0	37.4	28	0	121	99	0	34	34	34
2025	10	31	14	22	15	24.1	-2.8	1.036	0.3	0.2	0	37.4	28.4	0	122	100	0	35	34	34
2025	10	31	14	32	15	24.2	-1.7	1.035	0.5	0.4	0	37.8	29.2	0	123	101	0	35	33	35
2025	10	31	14	42	15	25.5	-3	1.035	0.4	0.3	0	37.8	28.4	0	123	100	0	35	34	34
2025	10	31	14	52	15	24.1	-2	1.035	0.4	0.3	0	38.7	29.7	0	124	102	0	34	33	34
2025	10	31	15	2	15	23.5	-2.6	1.035	0.4	0.3	0	38.7	29.2	0	125	102	0	35	34	34
2025	10	31	15	12	15	23.7	-3.3	1.034	0.5	0.4	0	38.3	28.8	0	123	101	0	34	34	35
2025	10	31	15	22	15	24.2	-2.8	1.034	0.4	0.3	0	37.8	28.8	0	123	101	0	35	34	34
2025	10	31	15	32	15	23.3	-1.5	1.034	0.4	0.3	0	38.7	29.2	0	124	102	0	34	34	34
2025	10	31	15	42	15	25.5	-2.8	1.033	0.4	0.3	0	38.7	29.2	0	124	101	0	34	33	34
2025	10	31	15	52	15	25.2	-3.4	1.034	0.4	0.3	0	38.7	28.8	0	124	101	0	34	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	10	31	16	2	15	23.9	-2.3	1.033	0.4	0.3	0	38.3	28.8	0	124	101	0	35	34	34
2025	10	31	16	12	15	25	-2.7	1.033	0.3	0.2	0	38.3	29.2	0	124	101	0	35	33	34
2025	10	31	16	22	15	25	-3	1.033	0.3	0.2	0	37.4	28.4	0	123	100	0	36	34	34
2025	10	31	16	32	15	24.4	-3.9	1.033	0.3	0.2	0	38.3	28.4	0	123	100	0	34	34	35
2025	10	31	16	42	15	25.3	-4.5	1.033	0.5	0.4	0	37.8	28.4	0	123	100	0	35	34	35
2025	10	31	16	52	15	25.4	-2.7	1.033	0.4	0.3	0	38.3	28.4	0	123	100	0	34	34	34
2025	10	31	17	2	15	24.8	-3.8	1.033	0.5	0.4	0	37.8	28	0	123	99	0	35	34	34
2025	10	31	17	12	15	25.4	-2.8	1.033	0.4	0.3	0	38.3	28.4	0	123	100	0	34	34	35
2025	10	31	17	22	15	25.6	-3.8	1.033	0.5	0.4	0	38.3	28.8	0	123	100	0	34	33	34
2025	10	31	17	32	15	24.6	-2.1	1.033	0.3	0.2	0	38.7	29.2	0	124	101	0	34	33	35
2025	10	31	17	42	15	26.2	-3.1	1.033	0.3	0.2	0	38.3	28.8	0	124	100	0	35	33	35
2025	10	31	17	52	15	25.5	-3.3	1.033	0.5	0.4	0	38.3	28.8	0	124	101	0	35	34	34
2025	10	31	18	2	15	24.3	-2.1	1.033	0.4	0.3	0	38.7	29.2	0	125	102	0	35	34	34
2025	10	31	18	12	15	25.1	-2.2	1.033	0.5	0.4	0	40	30.1	0	128	103	0	35	33	34
2025	10	31	18	22	15	25.5	-2.8	1.033	0.4	0.3	0	40.4	30.5	0	129	104	0	35	33	34
2025	10	31	18	32	15	24.9	-3.1	1.033	0.4	0.3	0	40.4	29.7	0	128	103	0	34	34	35
2025	10	31	18	42	15	24.2	-2.6	1.033	0.4	0.3	0	40.4	31	0	129	105	0	35	33	35
2025	10	31	18	52	15	24.5	-3	1.033	0.5	0.4	0	40.9	30.5	0	130	105	0	35	34	34
2025	10	31	19	2	15	25.6	-2.5	1.033	0.5	0.4	0	40.9	30.5	0	130	105	0	35	34	36
2025	10	31	19	12	15	23.6	-3.5	1.033	0.4	0.3	0	41.3	31.4	0	130	107	0	34	34	35
2025	10	31	19	22	15	24.9	-3.4	1.033	0.4	0.3	0	40.9	31	0	130	106	0	35	34	34
2025	10	31	19	32	15	24.5	-2.6	1.032	0.5	0.5	0	41.7	32.3	0	132	108	0	35	33	35
2025	10	31	19	42	15	24.4	-2.8	1.033	0.4	0.3	0	42.1	31.8	0	132	108	0	34	34	34
2025	10	31	19	52	15	24.1	-2.7	1.032	0.5	0.4	0	41.7	32.7	0	132	109	0	35	33	35
2025	10	31	20	2	15	25.3	-4.1	1.032	0.5	0.4	0	41.3	31.8	0	131	108	0	35	34	34
2025	10	31	20	12	15	26.6	-3.1	1.032	0.5	0.4	0	41.7	31.4	0	131	107	0	34	34	34
2025	10	31	20	22	15	24.4	-2.7	1.032	0.5	0.4	0	41.3	31.4	0	130	107	0	34	34	34
2025	10	31	20	32	15	25.8	-2.8	1.033	0.4	0.3	0	41.3	31.4	0	131	107	0	35	34	34
2025	10	31	20	42	15	24.9	-2.4	1.032	0.5	0.4	0	41.3	31.8	0	131	108	0	35	34	35
2025	10	31	20	52	15	24.5	-2.5	1.032	0.3	0.2	0	41.3	31.8	0	131	107	0	35	33	35
2025	10	31	21	2	15	25.6	-2.7	1.032	0.4	0.3	0	41.7	32.3	0	132	108	0	35	33	35
2025	10	31	21	12	15	25.5	-3.1	1.032	0.5	0.5	0	41.7	31.8	0	132	108	0	35	34	35
2025	10	31	21	22	15	25.5	-3	1.032	0.6	0.5	0	41.7	32.3	0	132	108	0	35	33	35
2025	10	31	21	32	15	25.4	-2.5	1.032	0.4	0.3	0	41.3	31.4	0	131	107	0	35	34	34
2025	10	31	21	42	15	25.6	-3	1.032	0.4	0.3	0	41.3	31.4	0	131	107	0	35	34	34
2025	10	31	21	52	15	24.9	-2.7	1.032	0.5	0.4	0	40.9	31.4	0	130	107	0	35	34	34
2025	10	31	22	2	15	25.1	-2.9	1.032	0.5	0.4	0	40.9	32.3	0	130	108	0	35	33	35
2025	10	31	22	12	15	25.4	-2.5	1.031	0.4	0.3	0	42.1	31.8	0	133	107	0	35	33	35
2025	10	31	22	22	15	25.1	-3	1.032	0.5	0.4	0	41.7	31.8	0	131	107	0	34	33	35
2025	10	31	22	32	15	25.1	-3.8	1.031	0.5	0.4	0	41.7	31.4	0	132	106	0	35	33	35
2025	10	31	22	42	15	25.2	-3	1.032	0.3	0.2	0	42.1	31.4	0	133	107	0	35	34	34
2025	10	31	22	52	15	25.5	-2.6	1.031	0.4	0.3	0	42.6	31.8	0	133	107	0	34	33	34
2025	10	31	23	2	15	25.7	-3.2	1.031	0.5	0.5	0	41.7	31.4	0	132	107	0	35	34	34
2025	10	31	23	12	15	25.7	-2.4	1.032	0.5	0.4	0	42.1	31.8	0	133	107	0	35	33	34
2025	10	31	23	22	15	25.6	-3.3	1.031	0.5	0.4	0	41.7	31.4	0	132	107	0	35	34	34
2025	10	31	23	32	15	24.8	-2.8	1.031	0.3	0.2	0	41.7	31.4	0	132	107	0	35	34	35
2025	10	31	23	42	15	25.1	-3.1	1.031	0.5	0.4	0	42.1	31.8	0	132	107	0	34	33	35
2025	10	31	23	52	15	25.2	-3	1.031	0.3	0.2	0	41.7	31.4	0	132	107	0	35	34	34

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	1	0	0	30	0	0	0	0	0	0	0	17.12	0	0	11	0.1	1.2
2025	10	1	0	10	30	0	0	0	0	0	0	0	17.11	0	0	11	0.1	1.2
2025	10	1	0	20	30	0	0	0	0	0	0	0	17.1	0	0	11	0.1	1.2
2025	10	1	0	30	30	0	0	0	0	0	0	0	17.1	0	0	11	0.1	1.2
2025	10	1	0	40	30	0	0	0	0	0	0	0	17.09	0	0	11	0.1	1.2
2025	10	1	0	50	30	0	0	0	0	0	0	0	17.09	0	0	11	0.1	1.2
2025	10	1	1	0	30	0	0	0	0	0	0	0	17.08	0	0	11	0.1	1.2
2025	10	1	1	10	30	0	0	0	0	0	0	0	17.08	0	0	11	0.1	1.2
2025	10	1	1	20	30	0	0	0	0	0	0	0	17.07	0	0	11	0.1	1.2
2025	10	1	1	30	30	0	0	0	0	0	0	0	17.07	0	0	11	0.1	1.2
2025	10	1	1	40	30	0	0	0	0	0	0	0	17.06	0	0	11	0.1	1.2
2025	10	1	1	50	30	0	0	0	0	0	0	0	17.06	0	0	11	0.1	1.2
2025	10	1	2	0	30	0	0	0	0	0	0	0	17.05	0	0	11	0.1	1.2
2025	10	1	2	10	30	0	0	0	0	0	0	0	17.05	0	0	11	0.1	1.2
2025	10	1	2	20	30	0	0	0	0	0	0	0	17.05	0	0	11	0.1	1.2
2025	10	1	2	30	30	0	0	0	0	0	0	0	17.04	0	0	11	0.1	1.2
2025	10	1	2	40	30	0	0	0	0	0	0	0	17.04	0	0	11	0.1	1.2
2025	10	1	2	50	30	0	0	0	0	0	0	0	17.03	0	0	11	0.1	1.2
2025	10	1	3	0	30	0	0	0	0	0	0	0	17.03	0	0	11	0.1	1.2
2025	10	1	3	10	30	0	0	0	0	0	0	0	17.03	0	0	11	0.1	1.2
2025	10	1	3	20	30	0	0	0	0	0	0	0	17.02	0	0	11	0.1	1.2
2025	10	1	3	30	30	0	0	0	0	0	0	0	17.01	0	0	11	0.1	1.2
2025	10	1	3	40	30	0	0	0	0	0	0	0	17	0	0	11	0.1	1.2
2025	10	1	3	50	30	0	0	0	0	0	0	0	16.99	0	0	11	0.1	1.2
2025	10	1	4	0	30	0	0	0	0	0	0	0	16.99	0	0	11	0.1	1.2
2025	10	1	4	10	30	0	0	0	0	0	0	0	16.98	0	0	11	0.1	1.2
2025	10	1	4	20	30	0	0	0	0	0	0	0	16.97	0	0	11	0.1	1.2
2025	10	1	4	30	30	0	0	0	0	0	0	0	16.95	0	0	11.2	0.1	1.2
2025	10	1	4	40	30	0	0	0	0	0	0	0	16.94	0	0	11.4	0.1	1.2
2025	10	1	4	50	30	0	0	0	0	0	0	0	16.93	0	0	11.4	0.1	1.2
2025	10	1	5	0	30	0	0	0	0	0	0	0	16.92	0	0	11.4	0.1	1.2
2025	10	1	5	10	30	0	0	0	0	0	0	0	16.91	0	0	11.4	0.1	1.2
2025	10	1	5	20	30	0	0	0	0	0	0	0	16.9	0	0	11.4	0.1	1.2
2025	10	1	5	30	30	0	0	0	0	0	0	0	16.89	0	0	11.4	0.1	1.2
2025	10	1	5	40	30	0	0	0	0	0	0	0	16.88	0	0	11.4	0.1	1.2
2025	10	1	5	50	30	0	0	0	0	0	0	0	16.86	0	0	11.4	0.1	1.2
2025	10	1	6	0	30	0	0	0	0	0	0	0	16.85	0	0	11.4	0.1	1.2
2025	10	1	6	10	30	0	0	0	0	0	0	0	16.83	0	0	11.4	0.1	1.2
2025	10	1	6	20	30	0	0	0	0	0	0	0	16.82	0	0	11.4	0.1	1.2
2025	10	1	6	30	30	0	0	0	0	0	0	0	16.81	0	0	11.4	0.1	1.2
2025	10	1	6	40	30	0	0	0	0	0	0	0	16.79	0	0	11.4	0.1	1.2
2025	10	1	6	50	30	0	0	0	0	0	0	0	16.78	0	0	11.4	0.1	1.2
2025	10	1	7	0	30	0	0	0	0	0	0	0	16.77	0	0	11.4	0.1	1.2
2025	10	1	7	10	30	0	0	0	0	0	0	0	16.75	0	0	11.4	0.1	1.2
2025	10	1	7	20	30	0	0	0	0	0	0	0	16.74	0	0	11.4	0.1	1.2
2025	10	1	7	30	30	0	0	0	0	0	0	0	16.72	0	0	11.4	0.1	1.2
2025	10	1	7	40	30	0	0	0	0	0	0	0	16.71	0	0	11.6	0.1	1.2
2025	10	1	7	50	30	0	0	0	0	0	0	0	16.69	0	0	11.8	0.1	1.2

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	1	8	0	30	0	0	0	0	0	0	0	16.69	0	0	12	0.1	1.2
2025	10	1	8	10	30	0	0	0	0	0	0	0	16.68	0	0	12.2	0.1	1.2
2025	10	1	8	20	30	0	0	0	0	0	0	0	16.68	0	0	12.2	0.1	1.2
2025	10	1	8	30	30	0	0	0	0	0	0	0	16.67	0	0	12.4	0.1	1.2
2025	10	1	8	40	30	0	0	0	0	0	0	0	16.67	0	0	12	0.1	1.2
2025	10	1	8	50	30	0	0	0	0	0	0	0	16.69	0	0	12.2	0.1	1.2
2025	10	1	9	0	30	0	0	0	0	0	0	0	16.72	0	0	12.2	0.1	1.2
2025	10	1	9	10	30	0	0	0	0	0	0	0	16.74	0	0	12.2	0.1	1.2
2025	10	1	9	20	30	0	0	0	0	0	0	0	16.75	0	0	12.4	0.1	1.2
2025	10	1	9	30	30	0	0	0	0	0	0	0	16.77	0	0	12.4	0.1	1.2
2025	10	1	9	40	30	0	0	0	0	0	0	0	16.78	0	0	12.6	0.1	1.2
2025	10	1	9	50	30	0	0	0	0	0	0	0	16.79	0	0	13	0.1	1.2
2025	10	1	10	0	30	0	0	0	0	0	0	0	16.81	0	0	13.2	0.1	1.2
2025	10	1	10	10	30	0	0	0	0	0	0	0	16.83	0	0	13.2	0.1	1.2
2025	10	1	10	20	30	0	0	0	0	0	0	0	16.84	0	0	14.2	0.1	1.2
2025	10	1	10	30	30	0	0	0	0	0	0	0	16.86	0	0	14	0.1	1.2
2025	10	1	10	40	30	0	0	0	0	0	0	0	16.88	0	0	14.2	0.1	1.2
2025	10	1	10	50	30	0	0	0	0	0	0	0	16.89	0	0	14.2	0.1	1.2
2025	10	1	11	0	30	0	0	0	0	0	0	0	16.92	0	0	14.2	0.1	1.2
2025	10	1	11	10	30	0	0	0	0	0	0	0	16.93	0	0	14.2	0.1	1.2
2025	10	1	11	20	30	0	0	0	0	0	0	0	16.96	0	0	14.2	0.1	1.2
2025	10	1	11	30	30	0	0	0	0	0	0	0	16.98	0	0	14.2	0.1	1.2
2025	10	1	11	40	30	0	0	0	0	0	0	0	17	0	0	14.2	0.1	1.2
2025	10	1	11	50	30	0	0	0	0	0	0	0	17.03	0	0	14.2	0.1	1.2
2025	10	1	12	0	30	0	0	0	0	0	0	0	17.03	0	0	14.2	0.1	1.2
2025	10	1	12	10	30	0	0	0	0	0	0	0	17.06	0	0	14.2	0.1	1.2
2025	10	1	12	20	30	0	0	0	0	0	0	0	17.08	0	0	14.2	0.1	1.2
2025	10	1	12	30	30	0	0	0	0	0	0	0	17.09	0	0	14.2	0.1	1.2
2025	10	1	12	40	30	0	0	0	0	0	0	0	17.11	0	0	14.2	0.1	1.2
2025	10	1	12	50	30	0	0	0	0	0	0	0	17.13	0	0	14.2	0.1	1.2
2025	10	1	13	0	30	0	0	0	0	0	0	0	17.14	0	0	14.2	0.1	1.2
2025	10	1	13	10	30	0	0	0	0	0	0	0	17.15	0	0	14.2	0.1	1.2
2025	10	1	13	20	30	0	0	0	0	0	0	0	17.16	0	0	14.2	0.1	1.2
2025	10	1	13	30	30	0	0	0	0	0	0	0	17.16	0	0	13.2	0.1	1.2
2025	10	1	13	40	30	0	0	0	0	0	0	0	17.17	0	0	13.2	0.1	1.2
2025	10	1	13	50	30	0	0	0	0	0	0	0	17.18	0	0	13.2	0.1	1.2
2025	10	1	14	0	30	0	0	0	0	0	0	0	17.18	0	0	13.2	0.1	1.2
2025	10	1	14	10	30	0	0	0	0	0	0	0	17.19	0	0	13.2	0.1	1.2
2025	10	1	14	20	30	0	0	0	0	0	0	0	17.19	0	0	13.2	0.1	1.2
2025	10	1	14	30	30	0	0	0	0	0	0	0	17.19	0	0	13.2	0.1	1.2
2025	10	1	14	40	30	0	0	0	0	0	0	0	17.19	0	0	13.2	0.1	1.2
2025	10	1	14	50	30	0	0	0	0	0	0	0	17.19	0	0	13.2	0.1	1.2
2025	10	1	15	0	30	0	0	0	0	0	0	0	17.18	0	0	13.2	0.1	1.2
2025	10	1	15	10	30	0	0	0	0	0	0	0	17.18	0	0	13.2	0.1	1.2
2025	10	1	15	20	30	0	0	0	0	0	0	0	17.18	0	0	13.2	0.1	1.2
2025	10	1	15	30	30	0	0	0	0	0	0	0	17.17	0	0	13.2	0.1	1.2
2025	10	1	15	40	30	0	0	0	0	0	0	0	17.16	0	0	13.2	0.1	1.2
2025	10	1	15	50	30	0	0	0	0	0	0	0	17.15	0	0	13.2	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	1	16	0	30	0	0	0	0	0	0	0	17.14	0	0	13.2	0.1	1.2
2025	10	1	16	10	30	0	0	0	0	0	0	0	17.13	0	0	13.2	0.1	1.2
2025	10	1	16	20	30	0	0	0	0	0	0	0	17.11	0	0	13	0.1	1.2
2025	10	1	16	30	30	0	0	0	0	0	0	0	17.09	0	0	12.6	0.1	1.2
2025	10	1	16	40	30	0	0	0	0	0	0	0	17.08	0	0	12.2	0.1	1.2
2025	10	1	16	50	30	0	0	0	0	0	0	0	17.07	0	0	12.2	0.1	1.2
2025	10	1	17	0	30	0	0	0	0	0	0	0	17.05	0	0	12	0.1	1.2
2025	10	1	17	10	30	0	0	0	0	0	0	0	17.02	0	0	12	0.1	1.2
2025	10	1	17	20	30	0	0	0	0	0	0	0	17	0	0	11.8	0.1	1.2
2025	10	1	17	30	30	0	0	0	0	0	0	0	16.98	0	0	11.6	0.1	1.2
2025	10	1	17	40	30	0	0	0	0	0	0	0	16.97	0	0	11.6	0.1	1.2
2025	10	1	17	50	30	0	0	0	0	0	0	0	16.95	0	0	11.6	0.1	1.2
2025	10	1	18	0	30	0	0	0	0	0	0	0	16.93	0	0	11.6	0.1	1.2
2025	10	1	18	10	30	0	0	0	0	0	0	0	16.92	0	0	11.6	0.1	1.2
2025	10	1	18	20	30	0	0	0	0	0	0	0	16.9	0	0	11.4	0.1	1.2
2025	10	1	18	30	30	0	0	0	0	0	0	0	16.87	0	0	11.4	0.1	1.2
2025	10	1	18	40	30	0	0	0	0	0	0	0	16.86	0	0	11.4	0.1	1.2
2025	10	1	18	50	30	0	0	0	0	0	0	0	16.83	0	0	11.4	0.1	1.2
2025	10	1	19	0	30	0	0	0	0	0	0	0	16.82	0	0	11.4	0.1	1.2
2025	10	1	19	10	30	0	0	0	0	0	0	0	16.8	0	0	11.4	0.1	1.2
2025	10	1	19	20	30	0	0	0	0	0	0	0	16.78	0	0	11.4	0.1	1.2
2025	10	1	19	30	30	0	0	0	0	0	0	0	16.76	0	0	11.4	0.1	1.2
2025	10	1	19	40	30	0	0	0	0	0	0	0	16.75	0	0	11.4	0.1	1.2
2025	10	1	19	50	30	0	0	0	0	0	0	0	16.73	0	0	11.4	0.1	1.2
2025	10	1	20	0	30	0	0	0	0	0	0	0	16.71	0	0	11.4	0.1	1.2
2025	10	1	20	10	30	0	0	0	0	0	0	0	16.69	0	0	11.4	0.1	1.2
2025	10	1	20	20	30	0	0	0	0	0	0	0	16.68	0	0	11.4	0.1	1.2
2025	10	1	20	30	30	0	0	0	0	0	0	0	16.67	0	0	11.4	0.1	1.2
2025	10	1	20	40	30	0	0	0	0	0	0	0	16.66	0	0	11.4	0.1	1.2
2025	10	1	20	50	30	0	0	0	0	0	0	0	16.65	0	0	11.4	0.1	1.2
2025	10	1	21	0	30	0	0	0	0	0	0	0	16.64	0	0	11.4	0.1	1.2
2025	10	1	21	10	30	0	0	0	0	0	0	0	16.63	0	0	11.4	0.1	1.2
2025	10	1	21	20	30	0	0	0	0	0	0	0	16.62	0	0	11.4	0.1	1.2
2025	10	1	21	30	30	0	0	0	0	0	0	0	16.61	0	0	11.4	0.1	1.2
2025	10	1	21	40	30	0	0	0	0	0	0	0	16.6	0	0	11.4	0.1	1.2
2025	10	1	21	50	30	0	0	0	0	0	0	0	16.59	0	0	11.4	0.1	1.2
2025	10	1	22	0	30	0	0	0	0	0	0	0	16.59	0	0	11.4	0.1	1.2
2025	10	1	22	10	30	0	0	0	0	0	0	0	16.58	0	0	11.4	0.1	1.2
2025	10	1	22	20	30	0	0	0	0	0	0	0	16.57	0	0	11.4	0.1	1.2
2025	10	1	22	30	30	0	0	0	0	0	0	0	16.56	0	0	11.2	0.1	1.2
2025	10	1	22	40	30	0	0	0	0	0	0	0	16.55	0	0	11.2	0.1	1.2
2025	10	1	22	50	30	0	0	0	0	0	0	0	16.55	0	0	11.2	0.1	1.2
2025	10	1	23	0	30	0	0	0	0	0	0	0	16.54	0	0	11.2	0.1	1.2
2025	10	1	23	10	30	0	0	0	0	0	0	0	16.53	0	0	11.2	0.1	1.2
2025	10	1	23	20	30	0	0	0	0	0	0	0	16.53	0	0	11.2	0.1	1.2
2025	10	1	23	30	30	0	0	0	0	0	0	0	16.53	0	0	11.2	0.1	1.2
2025	10	1	23	40	30	0	0	0	0	0	0	0	16.53	0	0	11.2	0.1	1.2
2025	10	1	23	50	30	0	0	0	0	0	0	0	16.53	0	0	11.2	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	2	0	0	30	0	0	0	0	0	0	0	16.52	0	0	11.2	0.1	1.2
2025	10	2	0	10	30	0	0	0	0	0	0	0	16.52	0	0	11.2	0.1	1.2
2025	10	2	0	20	30	0	0	0	0	0	0	0	16.52	0	0	11.2	0.1	1.2
2025	10	2	0	30	30	0	0	0	0	0	0	0	16.51	0	0	11.2	0.1	1.2
2025	10	2	0	40	30	0	0	0	0	0	0	0	16.51	0	0	11.2	0.1	1.2
2025	10	2	0	50	30	0	0	0	0	0	0	0	16.5	0	0	11.2	0.1	1.2
2025	10	2	1	0	30	0	0	0	0	0	0	0	16.5	0	0	11.2	0.1	1.2
2025	10	2	1	10	30	0	0	0	0	0	0	0	16.5	0	0	11.2	0.1	1.2
2025	10	2	1	20	30	0	0	0	0	0	0	0	16.49	0	0	11.2	0.1	1.2
2025	10	2	1	30	30	0	0	0	0	0	0	0	16.49	0	0	11.2	0.1	1.2
2025	10	2	1	40	30	0	0	0	0	0	0	0	16.49	0	0	11.2	0.1	1.2
2025	10	2	1	50	30	0	0	0	0	0	0	0	16.49	0	0	11.2	0.1	1.2
2025	10	2	2	0	30	0	0	0	0	0	0	0	16.49	0	0	11.2	0.1	1.2
2025	10	2	2	10	30	0	0	0	0	0	0	0	16.48	0	0	11.2	0.1	1.2
2025	10	2	2	20	30	0	0	0	0	0	0	0	16.48	0	0	11.2	0.1	1.2
2025	10	2	2	30	30	0	0	0	0	0	0	0	16.48	0	0	11.2	0.1	1.2
2025	10	2	2	40	30	0	0	0	0	0	0	0	16.48	0	0	11.2	0.1	1.2
2025	10	2	2	50	30	0	0	0	0	0	0	0	16.48	0	0	11.2	0.1	1.2
2025	10	2	3	0	30	0	0	0	0	0	0	0	16.47	0	0	11.2	0.1	1.2
2025	10	2	3	10	30	0	0	0	0	0	0	0	16.47	0	0	11.2	0.1	1.2
2025	10	2	3	20	30	0	0	0	0	0	0	0	16.47	0	0	11.2	0.1	1.2
2025	10	2	3	30	30	0	0	0	0	0	0	0	16.46	0	0	11.2	0.1	1.2
2025	10	2	3	40	30	0	0	0	0	0	0	0	16.46	0	0	11.2	0.1	1.2
2025	10	2	3	50	30	0	0	0	0	0	0	0	16.46	0	0	11.2	0.1	1.2
2025	10	2	4	0	30	0	0	0	0	0	0	0	16.46	0	0	11.2	0.1	1.2
2025	10	2	4	10	30	0	0	0	0	0	0	0	16.45	0	0	11.2	0.1	1.2
2025	10	2	4	20	30	0	0	0	0	0	0	0	16.45	0	0	11.2	0.1	1.2
2025	10	2	4	30	30	0	0	0	0	0	0	0	16.45	0	0	11.2	0.1	1.2
2025	10	2	4	40	30	0	0	0	0	0	0	0	16.44	0	0	11.2	0.1	1.2
2025	10	2	4	50	30	0	0	0	0	0	0	0	16.44	0	0	11.2	0.1	1.2
2025	10	2	5	0	30	0	0	0	0	0	0	0	16.43	0	0	11.2	0.1	1.2
2025	10	2	5	10	30	0	0	0	0	0	0	0	16.43	0	0	11.2	0.1	1.2
2025	10	2	5	20	30	0	0	0	0	0	0	0	16.42	0	0	11.2	0.1	1.2
2025	10	2	5	30	30	0	0	0	0	0	0	0	16.42	0	0	11.2	0.1	1.2
2025	10	2	5	40	30	0	0	0	0	0	0	0	16.41	0	0	11.2	0.1	1.2
2025	10	2	5	50	30	0	0	0	0	0	0	0	16.41	0	0	11.2	0.1	1.2
2025	10	2	6	0	30	0	0	0	0	0	0	0	16.4	0	0	11.2	0.1	1.2
2025	10	2	6	10	30	0	0	0	0	0	0	0	16.39	0	0	11.2	0.1	1.2
2025	10	2	6	20	30	0	0	0	0	0	0	0	16.38	0	0	11.2	0.1	1.2
2025	10	2	6	30	30	0	0	0	0	0	0	0	16.37	0	0	11.2	0.1	1.2
2025	10	2	6	40	30	0	0	0	0	0	0	0	16.36	0	0	11.2	0.1	1.2
2025	10	2	6	50	30	0	0	0	0	0	0	0	16.35	0	0	11.2	0.1	1.2
2025	10	2	7	0	30	0	0	0	0	0	0	0	16.35	0	0	11.2	0.1	1.2
2025	10	2	7	10	30	0	0	0	0	0	0	0	16.33	0	0	11.2	0.1	1.2
2025	10	2	7	20	30	0	0	0	0	0	0	0	16.32	0	0	11.2	0.1	1.2
2025	10	2	7	30	30	0	0	0	0	0	0	0	16.31	0	0	11.2	0.1	1.2
2025	10	2	7	40	30	0	0	0	0	0	0	0	16.3	0	0	11.4	0.1	1.2
2025	10	2	7	50	30	0	0	0	0	0	0	0	16.3	0	0	11.6	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	2	8	0	30	0	0	0	0	0	0	0	16.3	0	0	11.8	0.1	1.2
2025	10	2	8	10	30	0	0	0	0	0	0	0	16.29	0	0	12	0.1	1.2
2025	10	2	8	20	30	0	0	0	0	0	0	0	16.29	0	0	12	0.1	1.2
2025	10	2	8	30	30	0	0	0	0	0	0	0	16.29	0	0	12.2	0.1	1.2
2025	10	2	8	40	30	0	0	0	0	0	0	0	16.3	0	0	12.2	0.1	1.2
2025	10	2	8	50	30	0	0	0	0	0	0	0	16.31	0	0	12.2	0.1	1.2
2025	10	2	9	0	30	0	0	0	0	0	0	0	16.34	0	0	12.4	0.1	1.2
2025	10	2	9	10	30	0	0	0	0	0	0	0	16.35	0	0	12.4	0.1	1.2
2025	10	2	9	20	30	0	0	0	0	0	0	0	16.37	0	0	12.6	0.1	1.2
2025	10	2	9	30	30	0	0	0	0	0	0	0	16.38	0	0	12.4	0.1	1.2
2025	10	2	9	40	30	0	0	0	0	0	0	0	16.4	0	0	12.8	0.1	1.2
2025	10	2	9	50	30	0	0	0	0	0	0	0	16.41	0	0	13.2	0.1	1.2
2025	10	2	10	0	30	0	0	0	0	0	0	0	16.42	0	0	13.4	0.1	1.2
2025	10	2	10	10	30	0	0	0	0	0	0	0	16.44	0	0	13.6	0.1	1.2
2025	10	2	10	20	30	0	0	0	0	0	0	0	16.46	0	0	14.2	0.1	1.2
2025	10	2	10	30	30	0	0	0	0	0	0	0	16.48	0	0	14.2	0.1	1.2
2025	10	2	10	40	30	0	0	0	0	0	0	0	16.48	0	0	14.2	0.1	1.2
2025	10	2	10	50	30	0	0	0	0	0	0	0	16.5	0	0	14.2	0.1	1.2
2025	10	2	11	0	30	0	0	0	0	0	0	0	16.51	0	0	14.2	0.1	1.2
2025	10	2	11	10	30	0	0	0	0	0	0	0	16.53	0	0	14.2	0.1	1.2
2025	10	2	11	20	30	0	0	0	0	0	0	0	16.54	0	0	14.2	0.1	1.2
2025	10	2	11	30	30	0	0	0	0	0	0	0	16.56	0	0	13.2	0.1	1.2
2025	10	2	11	40	30	0	0	0	0	0	0	0	16.57	0	0	13.4	0.1	1.2
2025	10	2	11	50	30	0	0	0	0	0	0	0	16.59	0	0	13.4	0.1	1.2
2025	10	2	12	0	30	0	0	0	0	0	0	0	16.62	0	0	13.2	0.1	1.2
2025	10	2	12	10	30	0	0	0	0	0	0	0	16.64	0	0	13.2	0.1	1.2
2025	10	2	12	20	30	0	0	0	0	0	0	0	16.65	0	0	13.2	0.1	1.2
2025	10	2	12	30	30	0	0	0	0	0	0	0	16.66	0	0	13.2	0.1	1.2
2025	10	2	12	40	30	0	0	0	0	0	0	0	16.68	0	0	13.2	0.1	1.2
2025	10	2	12	50	30	0	0	0	0	0	0	0	16.7	0	0	13.2	0.1	1.2
2025	10	2	13	0	30	0	0	0	0	0	0	0	16.72	0	0	13.2	0.1	1.2
2025	10	2	13	10	30	0	0	0	0	0	0	0	16.73	0	0	13.2	0.1	1.2
2025	10	2	13	20	30	0	0	0	0	0	0	0	16.75	0	0	13.2	0.1	1.2
2025	10	2	13	30	30	0	0	0	0	0	0	0	16.76	0	0	13.2	0.1	1.2
2025	10	2	13	40	30	0	0	0	0	0	0	0	16.77	0	0	13.2	0.1	1.2
2025	10	2	13	50	30	0	0	0	0	0	0	0	16.79	0	0	13.2	0.1	1.2
2025	10	2	14	0	30	0	0	0	0	0	0	0	16.79	0	0	13.2	0.1	1.2
2025	10	2	14	10	30	0	0	0	0	0	0	0	16.81	0	0	13.2	0.1	1.2
2025	10	2	14	20	30	0	0	0	0	0	0	0	16.81	0	0	13.2	0.1	1.2
2025	10	2	14	30	30	0	0	0	0	0	0	0	16.81	0	0	13.2	0.1	1.2
2025	10	2	14	40	30	0	0	0	0	0	0	0	16.82	0	0	13.2	0.1	1.2
2025	10	2	14	50	30	0	0	0	0	0	0	0	16.82	0	0	13.2	0.1	1.2
2025	10	2	15	0	30	0	0	0	0	0	0	0	16.82	0	0	13.2	0.1	1.2
2025	10	2	15	10	30	0	0	0	0	0	0	0	16.81	0	0	13.2	0.1	1.2
2025	10	2	15	20	30	0	0	0	0	0	0	0	16.8	0	0	13.2	0.1	1.2
2025	10	2	15	30	30	0	0	0	0	0	0	0	16.79	0	0	13.4	0.1	1.2
2025	10	2	15	40	30	0	0	0	0	0	0	0	16.79	0	0	13.4	0.1	1.2
2025	10	2	15	50	30	0	0	0	0	0	0	0	16.78	0	0	13	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	2	16	0	30	0	0	0	0	0	0	0	16.74	0	0	12	0.1	1.2
2025	10	2	16	10	30	0	0	0	0	0	0	0	16.7	0	0	11.8	0.1	1.2
2025	10	2	16	20	30	0	0	0	0	0	0	0	16.69	0	0	11.6	0.1	1.2
2025	10	2	16	30	30	0	0	0	0	0	0	0	16.68	0	0	11.6	0.1	1.2
2025	10	2	16	40	30	0	0	0	0	0	0	0	16.66	0	0	11.6	0.1	1.2
2025	10	2	16	50	30	0	0	0	0	0	0	0	16.67	0	0	11.8	0.1	1.2
2025	10	2	17	0	30	0	0	0	0	0	0	0	16.65	0	0	11.6	0.1	1.2
2025	10	2	17	10	30	0	0	0	0	0	0	0	16.64	0	0	11.6	0.1	1.2
2025	10	2	17	20	30	0	0	0	0	0	0	0	16.63	0	0	11.6	0.1	1.2
2025	10	2	17	30	30	0	0	0	0	0	0	0	16.62	0	0	11.6	0.1	1.2
2025	10	2	17	40	30	0	0	0	0	0	0	0	16.6	0	0	11.6	0.1	1.2
2025	10	2	17	50	30	0	0	0	0	0	0	0	16.59	0	0	11.6	0.1	1.2
2025	10	2	18	0	30	0	0	0	0	0	0	0	16.57	0	0	11.4	0.1	1.2
2025	10	2	18	10	30	0	0	0	0	0	0	0	16.55	0	0	11.4	0.1	1.2
2025	10	2	18	20	30	0	0	0	0	0	0	0	16.53	0	0	11.4	0.1	1.2
2025	10	2	18	30	30	0	0	0	0	0	0	0	16.51	0	0	11.4	0.1	1.2
2025	10	2	18	40	30	0	0	0	0	0	0	0	16.49	0	0	11.4	0.1	1.2
2025	10	2	18	50	30	0	0	0	0	0	0	0	16.47	0	0	11.4	0.1	1.2
2025	10	2	19	0	30	0	0	0	0	0	0	0	16.45	0	0	11.4	0.1	1.2
2025	10	2	19	10	30	0	0	0	0	0	0	0	16.43	0	0	11.4	0.1	1.2
2025	10	2	19	20	30	0	0	0	0	0	0	0	16.41	0	0	11.4	0.1	1.2
2025	10	2	19	30	30	0	0	0	0	0	0	0	16.39	0	0	11.4	0.1	1.2
2025	10	2	19	40	30	0	0	0	0	0	0	0	16.38	0	0	11.4	0.1	1.2
2025	10	2	19	50	30	0	0	0	0	0	0	0	16.36	0	0	11.4	0.1	1.2
2025	10	2	20	0	30	0	0	0	0	0	0	0	16.35	0	0	11.4	0.1	1.2
2025	10	2	20	10	30	0	0	0	0	0	0	0	16.34	0	0	11.4	0.1	1.2
2025	10	2	20	20	30	0	0	0	0	0	0	0	16.32	0	0	11.4	0.1	1.2
2025	10	2	20	30	30	0	0	0	0	0	0	0	16.32	0	0	11.4	0.1	1.2
2025	10	2	20	40	30	0	0	0	0	0	0	0	16.31	0	0	11.4	0.1	1.2
2025	10	2	20	50	30	0	0	0	0	0	0	0	16.3	0	0	11.4	0.1	1.2
2025	10	2	21	0	30	0	0	0	0	0	0	0	16.29	0	0	11.4	0.1	1.2
2025	10	2	21	10	30	0	0	0	0	0	0	0	16.28	0	0	11.4	0.1	1.2
2025	10	2	21	20	30	0	0	0	0	0	0	0	16.28	0	0	11.4	0.1	1.2
2025	10	2	21	30	30	0	0	0	0	0	0	0	16.27	0	0	11.4	0.1	1.2
2025	10	2	21	40	30	0	0	0	0	0	0	0	16.26	0	0	11.4	0.1	1.2
2025	10	2	21	50	30	0	0	0	0	0	0	0	16.26	0	0	11.4	0.1	1.2
2025	10	2	22	0	30	0	0	0	0	0	0	0	16.25	0	0	11.4	0.1	1.2
2025	10	2	22	10	30	0	0	0	0	0	0	0	16.25	0	0	11.4	0.1	1.2
2025	10	2	22	20	30	0	0	0	0	0	0	0	16.25	0	0	11.4	0.1	1.2
2025	10	2	22	30	30	0	0	0	0	0	0	0	16.25	0	0	11.4	0.1	1.2
2025	10	2	22	40	30	0	0	0	0	0	0	0	16.25	0	0	11.4	0.1	1.2
2025	10	2	22	50	30	0	0	0	0	0	0	0	16.25	0	0	11.4	0.1	1.2
2025	10	2	23	0	30	0	0	0	0	0	0	0	16.25	0	0	11.4	0.1	1.2
2025	10	2	23	10	30	0	0	0	0	0	0	0	16.26	0	0	11.4	0.1	1.2
2025	10	2	23	20	30	0	0	0	0	0	0	0	16.26	0	0	11.4	0.1	1.2
2025	10	2	23	30	30	0	0	0	0	0	0	0	16.26	0	0	11.4	0.1	1.2
2025	10	2	23	40	30	0	0	0	0	0	0	0	16.27	0	0	11.4	0.1	1.2
2025	10	2	23	50	30	0	0	0	0	0	0	0	16.27	0	0	11.4	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	3	0	0	30	0	0	0	0	0	0	0	16.28	0	0	11.4	0.1	1.2
2025	10	3	0	10	30	0	0	0	0	0	0	0	16.29	0	0	11.2	0.1	1.2
2025	10	3	0	20	30	0	0	0	0	0	0	0	16.29	0	0	11.6	0.1	1.2
2025	10	3	0	30	30	0	0	0	0	0	0	0	16.3	0	0	11.6	0.1	1.2
2025	10	3	0	40	30	0	0	0	0	0	0	0	16.31	0	0	11.6	0.1	1.2
2025	10	3	0	50	30	0	0	0	0	0	0	0	16.32	0	0	11.6	0.1	1.2
2025	10	3	1	0	30	0	0	0	0	0	0	0	16.33	0	0	11.6	0.1	1.2
2025	10	3	1	10	30	0	0	0	0	0	0	0	16.34	0	0	11.6	0.1	1.2
2025	10	3	1	20	30	0	0	0	0	0	0	0	16.35	0	0	11.6	0.1	1.2
2025	10	3	1	30	30	0	0	0	0	0	0	0	16.35	0	0	11.6	0.1	1.2
2025	10	3	1	40	30	0	0	0	0	0	0	0	16.36	0	0	11.6	0.1	1.2
2025	10	3	1	50	30	0	0	0	0	0	0	0	16.37	0	0	11.6	0.1	1.2
2025	10	3	2	0	30	0	0	0	0	0	0	0	16.38	0	0	11.6	0.1	1.2
2025	10	3	2	10	30	0	0	0	0	0	0	0	16.39	0	0	11.6	0.1	1.2
2025	10	3	2	20	30	0	0	0	0	0	0	0	16.39	0	0	11.6	0.1	1.2
2025	10	3	2	30	30	0	0	0	0	0	0	0	16.4	0	0	11.6	0.1	1.2
2025	10	3	2	40	30	0	0	0	0	0	0	0	16.41	0	0	11.6	0.1	1.2
2025	10	3	2	50	30	0	0	0	0	0	0	0	16.41	0	0	11.6	0.1	1.2
2025	10	3	3	0	30	0	0	0	0	0	0	0	16.42	0	0	11.6	0.1	1.2
2025	10	3	3	10	30	0	0	0	0	0	0	0	16.43	0	0	11.6	0.1	1.2
2025	10	3	3	20	30	0	0	0	0	0	0	0	16.43	0	0	11.6	0.1	1.2
2025	10	3	3	30	30	0	0	0	0	0	0	0	16.44	0	0	11.6	0.1	1.2
2025	10	3	3	40	30	0	0	0	0	0	0	0	16.44	0	0	11.6	0.1	1.2
2025	10	3	3	50	30	0	0	0	0	0	0	0	16.44	0	0	11.6	0.1	1.2
2025	10	3	4	0	30	0	0	0	0	0	0	0	16.45	0	0	11.6	0.1	1.2
2025	10	3	4	10	30	0	0	0	0	0	0	0	16.45	0	0	11.6	0.1	1.2
2025	10	3	4	20	30	0	0	0	0	0	0	0	16.46	0	0	11.6	0.1	1.2
2025	10	3	4	30	30	0	0	0	0	0	0	0	16.46	0	0	11.6	0.1	1.2
2025	10	3	4	40	30	0	0	0	0	0	0	0	16.46	0	0	11.6	0.1	1.2
2025	10	3	4	50	30	0	0	0	0	0	0	0	16.47	0	0	11.6	0.1	1.2
2025	10	3	5	0	30	0	0	0	0	0	0	0	16.47	0	0	11.6	0.1	1.2
2025	10	3	5	10	30	0	0	0	0	0	0	0	16.48	0	0	11.6	0.1	1.2
2025	10	3	5	20	30	0	0	0	0	0	0	0	16.48	0	0	11.6	0.1	1.2
2025	10	3	5	30	30	0	0	0	0	0	0	0	16.49	0	0	11.6	0.1	1.2
2025	10	3	5	40	30	0	0	0	0	0	0	0	16.49	0	0	11.6	0.1	1.2
2025	10	3	5	50	30	0	0	0	0	0	0	0	16.49	0	0	11.6	0.1	1.2
2025	10	3	6	0	30	0	0	0	0	0	0	0	16.49	0	0	11.6	0.1	1.2
2025	10	3	6	10	30	0	0	0	0	0	0	0	16.5	0	0	11.6	0.1	1.2
2025	10	3	6	20	30	0	0	0	0	0	0	0	16.5	0	0	11.6	0.1	1.2
2025	10	3	6	30	30	0	0	0	0	0	0	0	16.48	0	0	11.6	0.1	1.2
2025	10	3	6	40	30	0	0	0	0	0	0	0	16.48	0	0	11.6	0.1	1.2
2025	10	3	6	50	30	0	0	0	0	0	0	0	16.48	0	0	11.6	0.1	1.2
2025	10	3	7	0	30	0	0	0	0	0	0	0	16.48	0	0	11.6	0.1	1.2
2025	10	3	7	10	30	0	0	0	0	0	0	0	16.47	0	0	11.6	0.1	1.2
2025	10	3	7	20	30	0	0	0	0	0	0	0	16.47	0	0	11.6	0.1	1.2
2025	10	3	7	30	30	0	0	0	0	0	0	0	16.46	0	0	11.6	0.1	1.2
2025	10	3	7	40	30	0	0	0	0	0	0	0	16.45	0	0	11.8	0.1	1.2
2025	10	3	7	50	30	0	0	0	0	0	0	0	16.44	0	0	12	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	3	8	0	30	0	0	0	0	0	0	0	16.44	0	0	12	0.1	1.2
2025	10	3	8	10	30	0	0	0	0	0	0	0	16.44	0	0	12.2	0.1	1.2
2025	10	3	8	20	30	0	0	0	0	0	0	0	16.44	0	0	12.2	0.1	1.2
2025	10	3	8	30	30	0	0	0	0	0	0	0	16.44	0	0	12.4	0.1	1.2
2025	10	3	8	40	30	0	0	0	0	0	0	0	16.44	0	0	12.4	0.1	1.2
2025	10	3	8	50	30	0	0	0	0	0	0	0	16.46	0	0	12.2	0.1	1.2
2025	10	3	9	0	30	0	0	0	0	0	0	0	16.48	0	0	12.2	0.1	1.2
2025	10	3	9	10	30	0	0	0	0	0	0	0	16.49	0	0	12.2	0.1	1.2
2025	10	3	9	20	30	0	0	0	0	0	0	0	16.5	0	0	12.2	0.1	1.2
2025	10	3	9	30	30	0	0	0	0	0	0	0	16.51	0	0	12.2	0.1	1.2
2025	10	3	9	40	30	0	0	0	0	0	0	0	16.52	0	0	12.4	0.1	1.2
2025	10	3	9	50	30	0	0	0	0	0	0	0	16.53	0	0	12.4	0.1	1.2
2025	10	3	10	0	30	0	0	0	0	0	0	0	16.54	0	0	12.6	0.1	1.2
2025	10	3	10	10	30	0	0	0	0	0	0	0	16.55	0	0	12.6	0.1	1.2
2025	10	3	10	20	30	0	0	0	0	0	0	0	16.56	0	0	12.8	0.1	1.2
2025	10	3	10	30	30	0	0	0	0	0	0	0	16.57	0	0	13.2	0.1	1.2
2025	10	3	10	40	30	0	0	0	0	0	0	0	16.58	0	0	13	0.1	1.2
2025	10	3	10	50	30	0	0	0	0	0	0	0	16.6	0	0	13	0.1	1.2
2025	10	3	11	0	30	0	0	0	0	0	0	0	16.6	0	0	13.2	0.1	1.2
2025	10	3	11	10	30	0	0	0	0	0	0	0	16.61	0	0	13.2	0.1	1.2
2025	10	3	11	20	30	0	0	0	0	0	0	0	16.62	0	0	13.2	0.1	1.2
2025	10	3	11	30	30	0	0	0	0	0	0	0	16.63	0	0	13.4	0.1	1.2
2025	10	3	11	40	30	0	0	0	0	0	0	0	16.64	0	0	13.4	0.1	1.2
2025	10	3	11	50	30	0	0	0	0	0	0	0	16.65	0	0	13.2	0.1	1.2
2025	10	3	12	0	30	0	0	0	0	0	0	0	16.66	0	0	13.6	0.1	1.2
2025	10	3	12	10	30	0	0	0	0	0	0	0	16.67	0	0	13.6	0.1	1.2
2025	10	3	12	20	30	0	0	0	0	0	0	0	16.68	0	0	13.6	0.1	1.2
2025	10	3	12	30	30	0	0	0	0	0	0	0	16.68	0	0	13.8	0.1	1.2
2025	10	3	12	40	30	0	0	0	0	0	0	0	16.71	0	0	14.2	0.1	1.2
2025	10	3	12	50	30	0	0	0	0	0	0	0	16.71	0	0	13.8	0.1	1.2
2025	10	3	13	0	30	0	0	0	0	0	0	0	16.73	0	0	14.2	0.1	1.2
2025	10	3	13	10	30	0	0	0	0	0	0	0	16.75	0	0	14.2	0.1	1.2
2025	10	3	13	20	30	0	0	0	0	0	0	0	16.75	0	0	14.2	0.1	1.2
2025	10	3	13	30	30	0	0	0	0	0	0	0	16.76	0	0	13.2	0.1	1.2
2025	10	3	13	40	30	0	0	0	0	0	0	0	16.77	0	0	13.2	0.1	1.2
2025	10	3	13	50	30	0	0	0	0	0	0	0	16.79	0	0	13.2	0.1	1.2
2025	10	3	14	0	30	0	0	0	0	0	0	0	16.8	0	0	13.2	0.1	1.2
2025	10	3	14	10	30	0	0	0	0	0	0	0	16.79	0	0	12.8	0.1	1.2
2025	10	3	14	20	30	0	0	0	0	0	0	0	16.67	0	0	11.8	0.1	1.2
2025	10	3	14	30	30	0	0	0	0	0	0	0	16.7	0	0	13.2	0.1	1.2
2025	10	3	14	40	30	0	0	0	0	0	0	0	16.74	0	0	13	0.1	1.2
2025	10	3	14	50	30	0	0	0	0	0	0	0	16.77	0	0	13	0.1	1.2
2025	10	3	15	0	30	0	0	0	0	0	0	0	16.78	0	0	13.2	0.1	1.2
2025	10	3	15	10	30	0	0	0	0	0	0	0	16.7	0	0	12.2	0.1	1.2
2025	10	3	15	20	30	0	0	0	0	0	0	0	16.67	0	0	12	0.1	1.2
2025	10	3	15	30	30	0	0	0	0	0	0	0	16.66	0	0	12	0.1	1.2
2025	10	3	15	40	30	0	0	0	0	0	0	0	16.64	0	0	12	0.1	1.2
2025	10	3	15	50	30	0	0	0	0	0	0	0	16.61	0	0	11.8	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	3	16	0	30	0	0	0	0	0	0	0	16.59	0	0	11.8	0.1	1.2
2025	10	3	16	10	30	0	0	0	0	0	0	0	16.57	0	0	11.6	0.1	1.2
2025	10	3	16	20	30	0	0	0	0	0	0	0	16.55	0	0	11.6	0.1	1.2
2025	10	3	16	30	30	0	0	0	0	0	0	0	16.53	0	0	11.6	0.1	1.2
2025	10	3	16	40	30	0	0	0	0	0	0	0	16.51	0	0	11.6	0.1	1.2
2025	10	3	16	50	30	0	0	0	0	0	0	0	16.49	0	0	11.6	0.1	1.2
2025	10	3	17	0	30	0	0	0	0	0	0	0	16.46	0	0	11.6	0.1	1.2
2025	10	3	17	10	30	0	0	0	0	0	0	0	16.45	0	0	11.6	0.1	1.2
2025	10	3	17	20	30	0	0	0	0	0	0	0	16.43	0	0	11.6	0.1	1.2
2025	10	3	17	30	30	0	0	0	0	0	0	0	16.41	0	0	11.6	0.1	1.2
2025	10	3	17	40	30	0	0	0	0	0	0	0	16.39	0	0	11.6	0.1	1.2
2025	10	3	17	50	30	0	0	0	0	0	0	0	16.37	0	0	11.6	0.1	1.2
2025	10	3	18	0	30	0	0	0	0	0	0	0	16.35	0	0	11.6	0.1	1.2
2025	10	3	18	10	30	0	0	0	0	0	0	0	16.33	0	0	11.6	0.1	1.2
2025	10	3	18	20	30	0	0	0	0	0	0	0	16.31	0	0	11.6	0.1	1.2
2025	10	3	18	30	30	0	0	0	0	0	0	0	16.29	0	0	11.6	0.1	1.2
2025	10	3	18	40	30	0	0	0	0	0	0	0	16.26	0	0	11.6	0.1	1.2
2025	10	3	18	50	30	0	0	0	0	0	0	0	16.25	0	0	11.4	0.1	1.2
2025	10	3	19	0	30	0	0	0	0	0	0	0	16.23	0	0	11.6	0.1	1.2
2025	10	3	19	10	30	0	0	0	0	0	0	0	16.21	0	0	11.6	0.1	1.2
2025	10	3	19	20	30	0	0	0	0	0	0	0	16.19	0	0	11.6	0.1	1.2
2025	10	3	19	30	30	0	0	0	0	0	0	0	16.17	0	0	11.6	0.1	1.2
2025	10	3	19	40	30	0	0	0	0	0	0	0	16.15	0	0	11.6	0.1	1.2
2025	10	3	19	50	30	0	0	0	0	0	0	0	16.14	0	0	11.6	0.1	1.2
2025	10	3	20	0	30	0	0	0	0	0	0	0	16.12	0	0	11.6	0.1	1.2
2025	10	3	20	10	30	0	0	0	0	0	0	0	16.11	0	0	11.4	0.1	1.2
2025	10	3	20	20	30	0	0	0	0	0	0	0	16.1	0	0	11.4	0.1	1.2
2025	10	3	20	30	30	0	0	0	0	0	0	0	16.08	0	0	11.4	0.1	1.2
2025	10	3	20	40	30	0	0	0	0	0	0	0	16.07	0	0	11.4	0.1	1.2
2025	10	3	20	50	30	0	0	0	0	0	0	0	16.05	0	0	11.4	0.1	1.2
2025	10	3	21	0	30	0	0	0	0	0	0	0	16.03	0	0	11.4	0.1	1.2
2025	10	3	21	10	30	0	0	0	0	0	0	0	16.02	0	0	11.4	0.1	1.2
2025	10	3	21	20	30	0	0	0	0	0	0	0	16	0	0	11.4	0.1	1.2
2025	10	3	21	30	30	0	0	0	0	0	0	0	15.98	0	0	11.4	0.1	1.2
2025	10	3	21	40	30	0	0	0	0	0	0	0	15.97	0	0	11.4	0.1	1.2
2025	10	3	21	50	30	0	0	0	0	0	0	0	15.96	0	0	11.4	0.1	1.2
2025	10	3	22	0	30	0	0	0	0	0	0	0	15.95	0	0	11.4	0.1	1.2
2025	10	3	22	10	30	0	0	0	0	0	0	0	15.94	0	0	11.4	0.1	1.2
2025	10	3	22	20	30	0	0	0	0	0	0	0	15.94	0	0	11.4	0.1	1.2
2025	10	3	22	30	30	0	0	0	0	0	0	0	15.94	0	0	11.4	0.1	1.2
2025	10	3	22	40	30	0	0	0	0	0	0	0	15.93	0	0	11.4	0.1	1.2
2025	10	3	22	50	30	0	0	0	0	0	0	0	15.93	0	0	11.4	0.1	1.2
2025	10	3	23	0	30	0	0	0	0	0	0	0	15.92	0	0	11.4	0.1	1.2
2025	10	3	23	10	30	0	0	0	0	0	0	0	15.92	0	0	11.4	0.1	1.2
2025	10	3	23	20	30	0	0	0	0	0	0	0	15.92	0	0	11.4	0.1	1.2
2025	10	3	23	30	30	0	0	0	0	0	0	0	15.92	0	0	11.4	0.1	1.2
2025	10	3	23	40	30	0	0	0	0	0	0	0	15.91	0	0	11.4	0.1	1.2
2025	10	3	23	50	30	0	0	0	0	0	0	0	15.92	0	0	11.4	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	4	0	0	30	0	0	0	0	0	0	0	15.91	0	0	11.4	0.1	1.2
2025	10	4	0	10	30	0	0	0	0	0	0	0	15.91	0	0	11.4	0.1	1.2
2025	10	4	0	20	30	0	0	0	0	0	0	0	15.92	0	0	11.4	0.1	1.2
2025	10	4	0	30	30	0	0	0	0	0	0	0	15.92	0	0	11.4	0.1	1.2
2025	10	4	0	40	30	0	0	0	0	0	0	0	15.92	0	0	11.4	0.1	1.2
2025	10	4	0	50	30	0	0	0	0	0	0	0	15.93	0	0	11.4	0.1	1.2
2025	10	4	1	0	30	0	0	0	0	0	0	0	15.93	0	0	11.4	0.1	1.2
2025	10	4	1	10	30	0	0	0	0	0	0	0	15.93	0	0	11.2	0.1	1.2
2025	10	4	1	20	30	0	0	0	0	0	0	0	15.93	0	0	11.2	0.1	1.2
2025	10	4	1	30	30	0	0	0	0	0	0	0	15.93	0	0	11.2	0.1	1.2
2025	10	4	1	40	30	0	0	0	0	0	0	0	15.92	0	0	11.2	0.1	1.2
2025	10	4	1	50	30	0	0	0	0	0	0	0	15.92	0	0	11.2	0.1	1.2
2025	10	4	2	0	30	0	0	0	0	0	0	0	15.92	0	0	11.2	0.1	1.2
2025	10	4	2	10	30	0	0	0	0	0	0	0	15.91	0	0	11.2	0.1	1.2
2025	10	4	2	20	30	0	0	0	0	0	0	0	15.91	0	0	11.2	0.1	1.2
2025	10	4	2	30	30	0	0	0	0	0	0	0	15.9	0	0	11.2	0.1	1.2
2025	10	4	2	40	30	0	0	0	0	0	0	0	15.89	0	0	11.2	0.1	1.2
2025	10	4	2	50	30	0	0	0	0	0	0	0	15.89	0	0	11.2	0.1	1.2
2025	10	4	3	0	30	0	0	0	0	0	0	0	15.88	0	0	11.2	0.1	1.2
2025	10	4	3	10	30	0	0	0	0	0	0	0	15.87	0	0	11.2	0.1	1.2
2025	10	4	3	20	30	0	0	0	0	0	0	0	15.86	0	0	11.2	0.1	1.2
2025	10	4	3	30	30	0	0	0	0	0	0	0	15.85	0	0	11.2	0.1	1.2
2025	10	4	3	40	30	0	0	0	0	0	0	0	15.84	0	0	11.2	0.1	1.2
2025	10	4	3	50	30	0	0	0	0	0	0	0	15.83	0	0	11.2	0.1	1.2
2025	10	4	4	0	30	0	0	0	0	0	0	0	15.82	0	0	11.2	0.1	1.2
2025	10	4	4	10	30	0	0	0	0	0	0	0	15.81	0	0	11.2	0.1	1.2
2025	10	4	4	20	30	0	0	0	0	0	0	0	15.79	0	0	11.2	0.1	1.2
2025	10	4	4	30	30	0	0	0	0	0	0	0	15.79	0	0	11.2	0.1	1.2
2025	10	4	4	40	30	0	0	0	0	0	0	0	15.77	0	0	11.2	0.1	1.2
2025	10	4	4	50	30	0	0	0	0	0	0	0	15.76	0	0	11.2	0.1	1.2
2025	10	4	5	0	30	0	0	0	0	0	0	0	15.75	0	0	11.2	0.1	1.2
2025	10	4	5	10	30	0	0	0	0	0	0	0	15.73	0	0	11.2	0.1	1.2
2025	10	4	5	20	30	0	0	0	0	0	0	0	15.72	0	0	11.2	0.1	1.2
2025	10	4	5	30	30	0	0	0	0	0	0	0	15.7	0	0	11.2	0.1	1.2
2025	10	4	5	40	30	0	0	0	0	0	0	0	15.69	0	0	11.2	0.1	1.2
2025	10	4	5	50	30	0	0	0	0	0	0	0	15.67	0	0	11.2	0.1	1.2
2025	10	4	6	0	30	0	0	0	0	0	0	0	15.66	0	0	11.2	0.1	1.2
2025	10	4	6	10	30	0	0	0	0	0	0	0	15.65	0	0	11.2	0.1	1.2
2025	10	4	6	20	30	0	0	0	0	0	0	0	15.63	0	0	11.2	0.1	1.2
2025	10	4	6	30	30	0	0	0	0	0	0	0	15.62	0	0	11.2	0.1	1.2
2025	10	4	6	40	30	0	0	0	0	0	0	0	15.61	0	0	11.2	0.1	1.2
2025	10	4	6	50	30	0	0	0	0	0	0	0	15.59	0	0	11.2	0.1	1.2
2025	10	4	7	0	30	0	0	0	0	0	0	0	15.58	0	0	11.2	0.1	1.2
2025	10	4	7	10	30	0	0	0	0	0	0	0	15.56	0	0	11.2	0.1	1.2
2025	10	4	7	20	30	0	0	0	0	0	0	0	15.55	0	0	11.2	0.1	1.2
2025	10	4	7	30	30	0	0	0	0	0	0	0	15.53	0	0	11.2	0.1	1.2
2025	10	4	7	40	30	0	0	0	0	0	0	0	15.51	0	0	11.4	0.1	1.2
2025	10	4	7	50	30	0	0	0	0	0	0	0	15.5	0	0	11.6	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	4	8	0	30	0	0	0	0	0	0	0	15.48	0	0	12	0.1	1.2
2025	10	4	8	10	30	0	0	0	0	0	0	0	15.47	0	0	12	0.1	1.2
2025	10	4	8	20	30	0	0	0	0	0	0	0	15.46	0	0	12.2	0.1	1.2
2025	10	4	8	30	30	0	0	0	0	0	0	0	15.45	0	0	12.2	0.1	1.2
2025	10	4	8	40	30	0	0	0	0	0	0	0	15.44	0	0	12.2	0.1	1.2
2025	10	4	8	50	30	0	0	0	0	0	0	0	15.45	0	0	12.4	0.1	1.2
2025	10	4	9	0	30	0	0	0	0	0	0	0	15.47	0	0	12.4	0.1	1.2
2025	10	4	9	10	30	0	0	0	0	0	0	0	15.48	0	0	12.4	0.1	1.2
2025	10	4	9	20	30	0	0	0	0	0	0	0	15.49	0	0	12.4	0.1	1.2
2025	10	4	9	30	30	0	0	0	0	0	0	0	15.49	0	0	12.6	0.1	1.2
2025	10	4	9	40	30	0	0	0	0	0	0	0	15.5	0	0	12.6	0.1	1.2
2025	10	4	9	50	30	0	0	0	0	0	0	0	15.51	0	0	12.8	0.1	1.2
2025	10	4	10	0	30	0	0	0	0	0	0	0	15.51	0	0	13.2	0.1	1.2
2025	10	4	10	10	30	0	0	0	0	0	0	0	15.52	0	0	13.4	0.1	1.2
2025	10	4	10	20	30	0	0	0	0	0	0	0	15.53	0	0	13.6	0.1	1.2
2025	10	4	10	30	30	0	0	0	0	0	0	0	15.54	0	0	13.6	0.1	1.2
2025	10	4	10	40	30	0	0	0	0	0	0	0	15.55	0	0	13.6	0.1	1.2
2025	10	4	10	50	30	0	0	0	0	0	0	0	15.56	0	0	13.6	0.1	1.2
2025	10	4	11	0	30	0	0	0	0	0	0	0	15.57	0	0	13.6	0.1	1.2
2025	10	4	11	10	30	0	0	0	0	0	0	0	15.59	0	0	13.6	0.1	1.2
2025	10	4	11	20	30	0	0	0	0	0	0	0	15.6	0	0	13.6	0.1	1.2
2025	10	4	11	30	30	0	0	0	0	0	0	0	15.62	0	0	13.6	0.1	1.2
2025	10	4	11	40	30	0	0	0	0	0	0	0	15.64	0	0	13.6	0.1	1.2
2025	10	4	11	50	30	0	0	0	0	0	0	0	15.65	0	0	13.6	0.1	1.2
2025	10	4	12	0	30	0	0	0	0	0	0	0	15.67	0	0	13.6	0.1	1.2
2025	10	4	12	10	30	0	0	0	0	0	0	0	15.69	0	0	13.4	0.1	1.2
2025	10	4	12	20	30	0	0	0	0	0	0	0	15.71	0	0	13.4	0.1	1.2
2025	10	4	12	30	30	0	0	0	0	0	0	0	15.72	0	0	13.4	0.1	1.2
2025	10	4	12	40	30	0	0	0	0	0	0	0	15.73	0	0	13.4	0.1	1.2
2025	10	4	12	50	30	0	0	0	0	0	0	0	15.75	0	0	13.4	0.1	1.2
2025	10	4	13	0	30	0	0	0	0	0	0	0	15.76	0	0	13.4	0.1	1.2
2025	10	4	13	10	30	0	0	0	0	0	0	0	15.77	0	0	13.4	0.1	1.2
2025	10	4	13	20	30	0	0	0	0	0	0	0	15.78	0	0	13.4	0.1	1.2
2025	10	4	13	30	30	0	0	0	0	0	0	0	15.78	0	0	13.4	0.1	1.2
2025	10	4	13	40	30	0	0	0	0	0	0	0	15.78	0	0	13.4	0.1	1.2
2025	10	4	13	50	30	0	0	0	0	0	0	0	15.79	0	0	13.4	0.1	1.2
2025	10	4	14	0	30	0	0	0	0	0	0	0	15.8	0	0	13.4	0.1	1.2
2025	10	4	14	10	30	0	0	0	0	0	0	0	15.81	0	0	13.4	0.1	1.2
2025	10	4	14	20	30	0	0	0	0	0	0	0	15.81	0	0	13.4	0.1	1.2
2025	10	4	14	30	30	0	0	0	0	0	0	0	15.81	0	0	13.4	0.1	1.2
2025	10	4	14	40	30	0	0	0	0	0	0	0	15.82	0	0	13.4	0.1	1.2
2025	10	4	14	50	30	0	0	0	0	0	0	0	15.82	0	0	13.4	0.1	1.2
2025	10	4	15	0	30	0	0	0	0	0	0	0	15.82	0	0	13.4	0.1	1.2
2025	10	4	15	10	30	0	0	0	0	0	0	0	15.82	0	0	13.2	0.1	1.2
2025	10	4	15	20	30	0	0	0	0	0	0	0	15.82	0	0	13.2	0.1	1.2
2025	10	4	15	30	30	0	0	0	0	0	0	0	15.81	0	0	13.2	0.1	1.2
2025	10	4	15	40	30	0	0	0	0	0	0	0	15.81	0	0	13	0.1	1.2
2025	10	4	15	50	30	0	0	0	0	0	0	0	15.8	0	0	13	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	4	16	0	30	0	0	0	0	0	0	0	15.8	0	0	13	0.1	1.2
2025	10	4	16	10	30	0	0	0	0	0	0	0	15.79	0	0	13	0.1	1.2
2025	10	4	16	20	30	0	0	0	0	0	0	0	15.79	0	0	13	0.1	1.2
2025	10	4	16	30	30	0	0	0	0	0	0	0	15.77	0	0	13	0.1	1.2
2025	10	4	16	40	30	0	0	0	0	0	0	0	15.76	0	0	12.4	0.1	1.2
2025	10	4	16	50	30	0	0	0	0	0	0	0	15.76	0	0	12.2	0.1	1.2
2025	10	4	17	0	30	0	0	0	0	0	0	0	15.75	0	0	12	0.1	1.2
2025	10	4	17	10	30	0	0	0	0	0	0	0	15.72	0	0	12	0.1	1.2
2025	10	4	17	20	30	0	0	0	0	0	0	0	15.72	0	0	11.8	0.1	1.2
2025	10	4	17	30	30	0	0	0	0	0	0	0	15.7	0	0	11.6	0.1	1.2
2025	10	4	17	40	30	0	0	0	0	0	0	0	15.7	0	0	11.6	0.1	1.2
2025	10	4	17	50	30	0	0	0	0	0	0	0	15.68	0	0	11.6	0.1	1.2
2025	10	4	18	0	30	0	0	0	0	0	0	0	15.68	0	0	11.6	0.1	1.2
2025	10	4	18	10	30	0	0	0	0	0	0	0	15.67	0	0	11.6	0.1	1.2
2025	10	4	18	20	30	0	0	0	0	0	0	0	15.65	0	0	11.6	0.1	1.2
2025	10	4	18	30	30	0	0	0	0	0	0	0	15.64	0	0	11.6	0.1	1.2
2025	10	4	18	40	30	0	0	0	0	0	0	0	15.62	0	0	11.6	0.1	1.2
2025	10	4	18	50	30	0	0	0	0	0	0	0	15.6	0	0	11.4	0.1	1.2
2025	10	4	19	0	30	0	0	0	0	0	0	0	15.59	0	0	11.4	0.1	1.2
2025	10	4	19	10	30	0	0	0	0	0	0	0	15.57	0	0	11.4	0.1	1.2
2025	10	4	19	20	30	0	0	0	0	0	0	0	15.55	0	0	11.4	0.1	1.2
2025	10	4	19	30	30	0	0	0	0	0	0	0	15.53	0	0	11.4	0.1	1.2
2025	10	4	19	40	30	0	0	0	0	0	0	0	15.51	0	0	11.4	0.1	1.2
2025	10	4	19	50	30	0	0	0	0	0	0	0	15.5	0	0	11.6	0.1	1.2
2025	10	4	20	0	30	0	0	0	0	0	0	0	15.48	0	0	11.6	0.1	1.2
2025	10	4	20	10	30	0	0	0	0	0	0	0	15.46	0	0	11.6	0.1	1.2
2025	10	4	20	20	30	0	0	0	0	0	0	0	15.44	0	0	11.6	0.1	1.2
2025	10	4	20	30	30	0	0	0	0	0	0	0	15.43	0	0	11.6	0.1	1.2
2025	10	4	20	40	30	0	0	0	0	0	0	0	15.42	0	0	11.6	0.1	1.2
2025	10	4	20	50	30	0	0	0	0	0	0	0	15.41	0	0	11.6	0.1	1.2
2025	10	4	21	0	30	0	0	0	0	0	0	0	15.4	0	0	11.6	0.1	1.2
2025	10	4	21	10	30	0	0	0	0	0	0	0	15.39	0	0	11.6	0.1	1.2
2025	10	4	21	20	30	0	0	0	0	0	0	0	15.38	0	0	11.6	0.1	1.2
2025	10	4	21	30	30	0	0	0	0	0	0	0	15.37	0	0	11.4	0.1	1.2
2025	10	4	21	40	30	0	0	0	0	0	0	0	15.36	0	0	11.4	0.1	1.2
2025	10	4	21	50	30	0	0	0	0	0	0	0	15.36	0	0	11.4	0.1	1.2
2025	10	4	22	0	30	0	0	0	0	0	0	0	15.35	0	0	11.4	0.1	1.2
2025	10	4	22	10	30	0	0	0	0	0	0	0	15.34	0	0	11.4	0.1	1.2
2025	10	4	22	20	30	0	0	0	0	0	0	0	15.33	0	0	11.4	0.1	1.2
2025	10	4	22	30	30	0	0	0	0	0	0	0	15.32	0	0	11.4	0.1	1.2
2025	10	4	22	40	30	0	0	0	0	0	0	0	15.31	0	0	11.4	0.1	1.2
2025	10	4	22	50	30	0	0	0	0	0	0	0	15.3	0	0	11.4	0.1	1.2
2025	10	4	23	0	30	0	0	0	0	0	0	0	15.29	0	0	11.4	0.1	1.2
2025	10	4	23	10	30	0	0	0	0	0	0	0	15.29	0	0	11.4	0.1	1.2
2025	10	4	23	20	30	0	0	0	0	0	0	0	15.28	0	0	11.4	0.1	1.2
2025	10	4	23	30	30	0	0	0	0	0	0	0	15.27	0	0	11.4	0.1	1.2
2025	10	4	23	40	30	0	0	0	0	0	0	0	15.26	0	0	11.4	0.1	1.2
2025	10	4	23	50	30	0	0	0	0	0	0	0	15.25	0	0	11.4	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	5	0	0	30	0	0	0	0	0	0	0	15.24	0	0	11.4	0.1	1.2
2025	10	5	0	10	30	0	0	0	0	0	0	0	15.24	0	0	11.4	0.1	1.2
2025	10	5	0	20	30	0	0	0	0	0	0	0	15.23	0	0	11.4	0.1	1.2
2025	10	5	0	30	30	0	0	0	0	0	0	0	15.23	0	0	11.4	0.1	1.2
2025	10	5	0	40	30	0	0	0	0	0	0	0	15.23	0	0	11.4	0.1	1.2
2025	10	5	0	50	30	0	0	0	0	0	0	0	15.21	0	0	11.4	0.1	1.2
2025	10	5	1	0	30	0	0	0	0	0	0	0	15.21	0	0	11.4	0.1	1.2
2025	10	5	1	10	30	0	0	0	0	0	0	0	15.21	0	0	11.6	0.1	1.2
2025	10	5	1	20	30	0	0	0	0	0	0	0	15.21	0	0	11.6	0.1	1.2
2025	10	5	1	30	30	0	0	0	0	0	0	0	15.21	0	0	11.6	0.1	1.2
2025	10	5	1	40	30	0	0	0	0	0	0	0	15.2	0	0	11.6	0.1	1.2
2025	10	5	1	50	30	0	0	0	0	0	0	0	15.2	0	0	11.6	0.1	1.2
2025	10	5	2	0	30	0	0	0	0	0	0	0	15.2	0	0	11.6	0.1	1.2
2025	10	5	2	10	30	0	0	0	0	0	0	0	15.2	0	0	11.6	0.1	1.2
2025	10	5	2	20	30	0	0	0	0	0	0	0	15.2	0	0	11.6	0.1	1.2
2025	10	5	2	30	30	0	0	0	0	0	0	0	15.2	0	0	11.6	0.1	1.2
2025	10	5	2	40	30	0	0	0	0	0	0	0	15.19	0	0	11.6	0.1	1.2
2025	10	5	2	50	30	0	0	0	0	0	0	0	15.19	0	0	11.6	0.1	1.2
2025	10	5	3	0	30	0	0	0	0	0	0	0	15.18	0	0	11.6	0.1	1.2
2025	10	5	3	10	30	0	0	0	0	0	0	0	15.18	0	0	11.6	0.1	1.2
2025	10	5	3	20	30	0	0	0	0	0	0	0	15.17	0	0	11.6	0.1	1.2
2025	10	5	3	30	30	0	0	0	0	0	0	0	15.17	0	0	11.6	0.1	1.2
2025	10	5	3	40	30	0	0	0	0	0	0	0	15.16	0	0	11.6	0.1	1.2
2025	10	5	3	50	30	0	0	0	0	0	0	0	15.16	0	0	11.6	0.1	1.2
2025	10	5	4	0	30	0	0	0	0	0	0	0	15.16	0	0	11.6	0.1	1.2
2025	10	5	4	10	30	0	0	0	0	0	0	0	15.15	0	0	11.6	0.1	1.2
2025	10	5	4	20	30	0	0	0	0	0	0	0	15.14	0	0	11.4	0.1	1.2
2025	10	5	4	30	30	0	0	0	0	0	0	0	15.14	0	0	11.4	0.1	1.2
2025	10	5	4	40	30	0	0	0	0	0	0	0	15.13	0	0	11.4	0.1	1.2
2025	10	5	4	50	30	0	0	0	0	0	0	0	15.12	0	0	11.4	0.1	1.2
2025	10	5	5	0	30	0	0	0	0	0	0	0	15.11	0	0	11.4	0.1	1.2
2025	10	5	5	10	30	0	0	0	0	0	0	0	15.1	0	0	11.4	0.1	1.2
2025	10	5	5	20	30	0	0	0	0	0	0	0	15.1	0	0	11.4	0.1	1.2
2025	10	5	5	30	30	0	0	0	0	0	0	0	15.09	0	0	11.4	0.1	1.2
2025	10	5	5	40	30	0	0	0	0	0	0	0	15.08	0	0	11.4	0.1	1.2
2025	10	5	5	50	30	0	0	0	0	0	0	0	15.07	0	0	11.4	0.1	1.2
2025	10	5	6	0	30	0	0	0	0	0	0	0	15.06	0	0	11.4	0.1	1.2
2025	10	5	6	10	30	0	0	0	0	0	0	0	15.05	0	0	11.4	0.1	1.2
2025	10	5	6	20	30	0	0	0	0	0	0	0	15.04	0	0	11.4	0.1	1.2
2025	10	5	6	30	30	0	0	0	0	0	0	0	15.03	0	0	11.4	0.1	1.2
2025	10	5	6	40	30	0	0	0	0	0	0	0	15.01	0	0	11.4	0.1	1.2
2025	10	5	6	50	30	0	0	0	0	0	0	0	15	0	0	11.4	0.1	1.2
2025	10	5	7	0	30	0	0	0	0	0	0	0	14.99	0	0	11.4	0.1	1.2
2025	10	5	7	10	30	0	0	0	0	0	0	0	14.97	0	0	11.4	0.1	1.2
2025	10	5	7	20	30	0	0	0	0	0	0	0	14.97	0	0	11.4	0.1	1.2
2025	10	5	7	30	30	0	0	0	0	0	0	0	14.95	0	0	11.4	0.1	1.2
2025	10	5	7	40	30	0	0	0	0	0	0	0	14.94	0	0	11.8	0.1	1.2
2025	10	5	7	50	30	0	0	0	0	0	0	0	14.92	0	0	12	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	5	8	0	30	0	0	0	0	0	0	0	14.92	0	0	12.2	0.1	1.2
2025	10	5	8	10	30	0	0	0	0	0	0	0	14.91	0	0	12.4	0.1	1.2
2025	10	5	8	20	30	0	0	0	0	0	0	0	14.91	0	0	12.4	0.1	1.2
2025	10	5	8	30	30	0	0	0	0	0	0	0	14.9	0	0	12.4	0.1	1.2
2025	10	5	8	40	30	0	0	0	0	0	0	0	14.9	0	0	12.6	0.1	1.2
2025	10	5	8	50	30	0	0	0	0	0	0	0	14.92	0	0	12.6	0.1	1.2
2025	10	5	9	0	30	0	0	0	0	0	0	0	14.94	0	0	12.6	0.1	1.2
2025	10	5	9	10	30	0	0	0	0	0	0	0	14.96	0	0	12.6	0.1	1.2
2025	10	5	9	20	30	0	0	0	0	0	0	0	14.98	0	0	12.8	0.1	1.2
2025	10	5	9	30	30	0	0	0	0	0	0	0	14.99	0	0	13	0.1	1.2
2025	10	5	9	40	30	0	0	0	0	0	0	0	15	0	0	13	0.1	1.2
2025	10	5	9	50	30	0	0	0	0	0	0	0	15.01	0	0	13.4	0.1	1.2
2025	10	5	10	0	30	0	0	0	0	0	0	0	15.03	0	0	14.2	0.1	1.2
2025	10	5	10	10	30	0	0	0	0	0	0	0	15.04	0	0	14.2	0.1	1.2
2025	10	5	10	20	30	0	0	0	0	0	0	0	15.06	0	0	14.2	0.1	1.2
2025	10	5	10	30	30	0	0	0	0	0	0	0	15.07	0	0	13.6	0.1	1.2
2025	10	5	10	40	30	0	0	0	0	0	0	0	15.09	0	0	13.6	0.1	1.2
2025	10	5	10	50	30	0	0	0	0	0	0	0	15.1	0	0	13.6	0.1	1.2
2025	10	5	11	0	30	0	0	0	0	0	0	0	15.12	0	0	13.6	0.1	1.2
2025	10	5	11	10	30	0	0	0	0	0	0	0	15.13	0	0	13.6	0.1	1.2
2025	10	5	11	20	30	0	0	0	0	0	0	0	15.15	0	0	13.6	0.1	1.2
2025	10	5	11	30	30	0	0	0	0	0	0	0	15.16	0	0	13.6	0.1	1.2
2025	10	5	11	40	30	0	0	0	0	0	0	0	15.18	0	0	13.6	0.1	1.2
2025	10	5	11	50	30	0	0	0	0	0	0	0	15.19	0	0	13.6	0.1	1.2
2025	10	5	12	0	30	0	0	0	0	0	0	0	15.21	0	0	13.6	0.1	1.2
2025	10	5	12	10	30	0	0	0	0	0	0	0	15.22	0	0	13.4	0.1	1.2
2025	10	5	12	20	30	0	0	0	0	0	0	0	15.24	0	0	13.4	0.1	1.2
2025	10	5	12	30	30	0	0	0	0	0	0	0	15.24	0	0	13.4	0.1	1.2
2025	10	5	12	40	30	0	0	0	0	0	0	0	15.26	0	0	13.4	0.1	1.2
2025	10	5	12	50	30	0	0	0	0	0	0	0	15.27	0	0	13.4	0.1	1.2
2025	10	5	13	0	30	0	0	0	0	0	0	0	15.28	0	0	13.4	0.1	1.2
2025	10	5	13	10	30	0	0	0	0	0	0	0	15.28	0	0	13.4	0.1	1.2
2025	10	5	13	20	30	0	0	0	0	0	0	0	15.29	0	0	13.4	0.1	1.2
2025	10	5	13	30	30	0	0	0	0	0	0	0	15.3	0	0	13.6	0.1	1.2
2025	10	5	13	40	30	0	0	0	0	0	0	0	15.31	0	0	13.6	0.1	1.2
2025	10	5	13	50	30	0	0	0	0	0	0	0	15.32	0	0	13.6	0.1	1.2
2025	10	5	14	0	30	0	0	0	0	0	0	0	15.31	0	0	13.8	0.1	1.2
2025	10	5	14	10	30	0	0	0	0	0	0	0	15.33	0	0	13.6	0.1	1.2
2025	10	5	14	20	30	0	0	0	0	0	0	0	15.32	0	0	14.2	0.1	1.2
2025	10	5	14	30	30	0	0	0	0	0	0	0	15.32	0	0	14.2	0.1	1.2
2025	10	5	14	40	30	0	0	0	0	0	0	0	15.32	0	0	14.2	0.1	1.2
2025	10	5	14	50	30	0	0	0	0	0	0	0	15.32	0	0	14.2	0.1	1.2
2025	10	5	15	0	30	0	0	0	0	0	0	0	15.31	0	0	14	0.1	1.2
2025	10	5	15	10	30	0	0	0	0	0	0	0	15.3	0	0	14	0.1	1.2
2025	10	5	15	20	30	0	0	0	0	0	0	0	15.29	0	0	14	0.1	1.2
2025	10	5	15	30	30	0	0	0	0	0	0	0	15.29	0	0	13.4	0.1	1.2
2025	10	5	15	40	30	0	0	0	0	0	0	0	15.28	0	0	13.4	0.1	1.2
2025	10	5	15	50	30	0	0	0	0	0	0	0	15.26	0	0	13.4	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	5	16	0	30	0	0	0	0	0	0	0	15.25	0	0	13.4	0.1	1.2
2025	10	5	16	10	30	0	0	0	0	0	0	0	15.24	0	0	13.4	0.1	1.2
2025	10	5	16	20	30	0	0	0	0	0	0	0	15.22	0	0	13.4	0.1	1.2
2025	10	5	16	30	30	0	0	0	0	0	0	0	15.19	0	0	13.2	0.1	1.2
2025	10	5	16	40	30	0	0	0	0	0	0	0	15.17	0	0	12.6	0.1	1.2
2025	10	5	16	50	30	0	0	0	0	0	0	0	15.16	0	0	12.4	0.1	1.2
2025	10	5	17	0	30	0	0	0	0	0	0	0	15.14	0	0	12.2	0.1	1.2
2025	10	5	17	10	30	0	0	0	0	0	0	0	15.12	0	0	12	0.1	1.2
2025	10	5	17	20	30	0	0	0	0	0	0	0	15.1	0	0	12	0.1	1.2
2025	10	5	17	30	30	0	0	0	0	0	0	0	15.08	0	0	11.8	0.1	1.2
2025	10	5	17	40	30	0	0	0	0	0	0	0	15.07	0	0	11.8	0.1	1.2
2025	10	5	17	50	30	0	0	0	0	0	0	0	15.05	0	0	11.6	0.1	1.2
2025	10	5	18	0	30	0	0	0	0	0	0	0	15.03	0	0	11.6	0.1	1.2
2025	10	5	18	10	30	0	0	0	0	0	0	0	15.01	0	0	11.6	0.1	1.2
2025	10	5	18	20	30	0	0	0	0	0	0	0	14.99	0	0	11.6	0.1	1.2
2025	10	5	18	30	30	0	0	0	0	0	0	0	14.97	0	0	11.6	0.1	1.2
2025	10	5	18	40	30	0	0	0	0	0	0	0	14.94	0	0	11.6	0.1	1.2
2025	10	5	18	50	30	0	0	0	0	0	0	0	14.92	0	0	11.6	0.1	1.2
2025	10	5	19	0	30	0	0	0	0	0	0	0	14.9	0	0	11.6	0.1	1.2
2025	10	5	19	10	30	0	0	0	0	0	0	0	14.87	0	0	11.6	0.1	1.2
2025	10	5	19	20	30	0	0	0	0	0	0	0	14.85	0	0	11.6	0.1	1.2
2025	10	5	19	30	30	0	0	0	0	0	0	0	14.82	0	0	11.6	0.1	1.2
2025	10	5	19	40	30	0	0	0	0	0	0	0	14.8	0	0	11.6	0.1	1.2
2025	10	5	19	50	30	0	0	0	0	0	0	0	14.78	0	0	11.6	0.1	1.2
2025	10	5	20	0	30	0	0	0	0	0	0	0	14.76	0	0	11.6	0.1	1.2
2025	10	5	20	10	30	0	0	0	0	0	0	0	14.73	0	0	11.6	0.1	1.2
2025	10	5	20	20	30	0	0	0	0	0	0	0	14.71	0	0	11.6	0.1	1.2
2025	10	5	20	30	30	0	0	0	0	0	0	0	14.7	0	0	11.6	0.1	1.2
2025	10	5	20	40	30	0	0	0	0	0	0	0	14.69	0	0	11.6	0.1	1.2
2025	10	5	20	50	30	0	0	0	0	0	0	0	14.67	0	0	11.6	0.1	1.2
2025	10	5	21	0	30	0	0	0	0	0	0	0	14.66	0	0	11.6	0.1	1.2
2025	10	5	21	10	30	0	0	0	0	0	0	0	14.64	0	0	11.6	0.1	1.2
2025	10	5	21	20	30	0	0	0	0	0	0	0	14.64	0	0	11.6	0.1	1.2
2025	10	5	21	30	30	0	0	0	0	0	0	0	14.62	0	0	11.6	0.1	1.2
2025	10	5	21	40	30	0	0	0	0	0	0	0	14.62	0	0	11.4	0.1	1.2
2025	10	5	21	50	30	0	0	0	0	0	0	0	14.61	0	0	11.4	0.1	1.2
2025	10	5	22	0	30	0	0	0	0	0	0	0	14.6	0	0	11.4	0.1	1.2
2025	10	5	22	10	30	0	0	0	0	0	0	0	14.6	0	0	11.4	0.1	1.2
2025	10	5	22	20	30	0	0	0	0	0	0	0	14.6	0	0	11.4	0.1	1.2
2025	10	5	22	30	30	0	0	0	0	0	0	0	14.59	0	0	11.4	0.1	1.2
2025	10	5	22	40	30	0	0	0	0	0	0	0	14.58	0	0	11.4	0.1	1.2
2025	10	5	22	50	30	0	0	0	0	0	0	0	14.58	0	0	11.4	0.1	1.2
2025	10	5	23	0	30	0	0	0	0	0	0	0	14.58	0	0	11.4	0.1	1.2
2025	10	5	23	10	30	0	0	0	0	0	0	0	14.58	0	0	11.4	0.1	1.2
2025	10	5	23	20	30	0	0	0	0	0	0	0	14.58	0	0	11.4	0.1	1.2
2025	10	5	23	30	30	0	0	0	0	0	0	0	14.57	0	0	11.4	0.1	1.2
2025	10	5	23	40	30	0	0	0	0	0	0	0	14.57	0	0	11.4	0.1	1.2
2025	10	5	23	50	30	0	0	0	0	0	0	0	14.57	0	0	11.4	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	6	0	0	30	0	0	0	0	0	0	0	14.56	0	0	11.4	0.1	1.2
2025	10	6	0	10	30	0	0	0	0	0	0	0	14.56	0	0	11.4	0.1	1.2
2025	10	6	0	20	30	0	0	0	0	0	0	0	14.56	0	0	11.4	0.1	1.2
2025	10	6	0	30	30	0	0	0	0	0	0	0	14.56	0	0	11.4	0.1	1.2
2025	10	6	0	40	30	0	0	0	0	0	0	0	14.56	0	0	11.4	0.1	1.2
2025	10	6	0	50	30	0	0	0	0	0	0	0	14.55	0	0	11.4	0.1	1.2
2025	10	6	1	0	30	0	0	0	0	0	0	0	14.56	0	0	11.4	0.1	1.2
2025	10	6	1	10	30	0	0	0	0	0	0	0	14.55	0	0	11.4	0.1	1.2
2025	10	6	1	20	30	0	0	0	0	0	0	0	14.55	0	0	11.4	0.1	1.2
2025	10	6	1	30	30	0	0	0	0	0	0	0	14.56	0	0	11.4	0.1	1.2
2025	10	6	1	40	30	0	0	0	0	0	0	0	14.56	0	0	11.4	0.1	1.2
2025	10	6	1	50	30	0	0	0	0	0	0	0	14.56	0	0	11.4	0.1	1.2
2025	10	6	2	0	30	0	0	0	0	0	0	0	14.56	0	0	11.4	0.1	1.2
2025	10	6	2	10	30	0	0	0	0	0	0	0	14.56	0	0	11.4	0.1	1.2
2025	10	6	2	20	30	0	0	0	0	0	0	0	14.57	0	0	11.4	0.1	1.2
2025	10	6	2	30	30	0	0	0	0	0	0	0	14.57	0	0	11.4	0.1	1.2
2025	10	6	2	40	30	0	0	0	0	0	0	0	14.57	0	0	11.4	0.1	1.2
2025	10	6	2	50	30	0	0	0	0	0	0	0	14.57	0	0	11.4	0.1	1.2
2025	10	6	3	0	30	0	0	0	0	0	0	0	14.57	0	0	11.4	0.1	1.2
2025	10	6	3	10	30	0	0	0	0	0	0	0	14.57	0	0	11.4	0.1	1.2
2025	10	6	3	20	30	0	0	0	0	0	0	0	14.57	0	0	11.4	0.1	1.2
2025	10	6	3	30	30	0	0	0	0	0	0	0	14.57	0	0	11.4	0.1	1.2
2025	10	6	3	40	30	0	0	0	0	0	0	0	14.57	0	0	11.4	0.1	1.2
2025	10	6	3	50	30	0	0	0	0	0	0	0	14.56	0	0	11.4	0.1	1.2
2025	10	6	4	0	30	0	0	0	0	0	0	0	14.56	0	0	11.4	0.1	1.2
2025	10	6	4	10	30	0	0	0	0	0	0	0	14.56	0	0	11.4	0.1	1.2
2025	10	6	4	20	30	0	0	0	0	0	0	0	14.56	0	0	11.4	0.1	1.2
2025	10	6	4	30	30	0	0	0	0	0	0	0	14.55	0	0	11.4	0.1	1.2
2025	10	6	4	40	30	0	0	0	0	0	0	0	14.55	0	0	11.4	0.1	1.2
2025	10	6	4	50	30	0	0	0	0	0	0	0	14.54	0	0	11.4	0.1	1.2
2025	10	6	5	0	30	0	0	0	0	0	0	0	14.54	0	0	11.4	0.1	1.2
2025	10	6	5	10	30	0	0	0	0	0	0	0	14.53	0	0	11.4	0.1	1.2
2025	10	6	5	20	30	0	0	0	0	0	0	0	14.52	0	0	11.4	0.1	1.2
2025	10	6	5	30	30	0	0	0	0	0	0	0	14.52	0	0	11.4	0.1	1.2
2025	10	6	5	40	30	0	0	0	0	0	0	0	14.51	0	0	11.4	0.1	1.2
2025	10	6	5	50	30	0	0	0	0	0	0	0	14.5	0	0	11.4	0.1	1.2
2025	10	6	6	0	30	0	0	0	0	0	0	0	14.49	0	0	11.4	0.1	1.2
2025	10	6	6	10	30	0	0	0	0	0	0	0	14.48	0	0	11.4	0.1	1.2
2025	10	6	6	20	30	0	0	0	0	0	0	0	14.48	0	0	11.4	0.1	1.2
2025	10	6	6	30	30	0	0	0	0	0	0	0	14.46	0	0	11.4	0.1	1.2
2025	10	6	6	40	30	0	0	0	0	0	0	0	14.45	0	0	11.4	0.1	1.2
2025	10	6	6	50	30	0	0	0	0	0	0	0	14.44	0	0	11.4	0.1	1.2
2025	10	6	7	0	30	0	0	0	0	0	0	0	14.44	0	0	11.4	0.1	1.2
2025	10	6	7	10	30	0	0	0	0	0	0	0	14.43	0	0	11.4	0.1	1.2
2025	10	6	7	20	30	0	0	0	0	0	0	0	14.42	0	0	11.4	0.1	1.2
2025	10	6	7	30	30	0	0	0	0	0	0	0	14.41	0	0	11.4	0.1	1.2
2025	10	6	7	40	30	0	0	0	0	0	0	0	14.41	0	0	11.6	0.1	1.2
2025	10	6	7	50	30	0	0	0	0	0	0	0	14.4	0	0	11.8	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	6	8	0	30	0	0	0	0	0	0	0	14.39	0	0	12	0.1	1.2
2025	10	6	8	10	30	0	0	0	0	0	0	0	14.39	0	0	12.2	0.1	1.2
2025	10	6	8	20	30	0	0	0	0	0	0	0	14.38	0	0	12.2	0.1	1.2
2025	10	6	8	30	30	0	0	0	0	0	0	0	14.38	0	0	12.4	0.1	1.2
2025	10	6	8	40	30	0	0	0	0	0	0	0	14.38	0	0	12.4	0.1	1.2
2025	10	6	8	50	30	0	0	0	0	0	0	0	14.41	0	0	12.4	0.1	1.2
2025	10	6	9	0	30	0	0	0	0	0	0	0	14.44	0	0	12.4	0.1	1.2
2025	10	6	9	10	30	0	0	0	0	0	0	0	14.45	0	0	12.6	0.1	1.2
2025	10	6	9	20	30	0	0	0	0	0	0	0	14.47	0	0	12.6	0.1	1.2
2025	10	6	9	30	30	0	0	0	0	0	0	0	14.48	0	0	12.6	0.1	1.2
2025	10	6	9	40	30	0	0	0	0	0	0	0	14.5	0	0	12.8	0.1	1.2
2025	10	6	9	50	30	0	0	0	0	0	0	0	14.51	0	0	12.8	0.1	1.2
2025	10	6	10	0	30	0	0	0	0	0	0	0	14.53	0	0	13.2	0.1	1.2
2025	10	6	10	10	30	0	0	0	0	0	0	0	14.55	0	0	14.2	0.1	1.2
2025	10	6	10	20	30	0	0	0	0	0	0	0	14.57	0	0	14.2	0.1	1.2
2025	10	6	10	30	30	0	0	0	0	0	0	0	14.59	0	0	13.6	0.1	1.2
2025	10	6	10	40	30	0	0	0	0	0	0	0	14.61	0	0	13.6	0.1	1.2
2025	10	6	10	50	30	0	0	0	0	0	0	0	14.63	0	0	13.6	0.1	1.2
2025	10	6	11	0	30	0	0	0	0	0	0	0	14.64	0	0	14.2	0.1	1.2
2025	10	6	11	10	30	0	0	0	0	0	0	0	14.66	0	0	14.2	0.1	1.2
2025	10	6	11	20	30	0	0	0	0	0	0	0	14.68	0	0	14.2	0.1	1.2
2025	10	6	11	30	30	0	0	0	0	0	0	0	14.7	0	0	14.2	0.1	1.2
2025	10	6	11	40	30	0	0	0	0	0	0	0	14.72	0	0	14.2	0.1	1.2
2025	10	6	11	50	30	0	0	0	0	0	0	0	14.74	0	0	14.2	0.1	1.2
2025	10	6	12	0	30	0	0	0	0	0	0	0	14.76	0	0	14.2	0.1	1.2
2025	10	6	12	10	30	0	0	0	0	0	0	0	14.78	0	0	14.2	0.1	1.2
2025	10	6	12	20	30	0	0	0	0	0	0	0	14.8	0	0	14.2	0.1	1.2
2025	10	6	12	30	30	0	0	0	0	0	0	0	14.81	0	0	14.2	0.1	1.2
2025	10	6	12	40	30	0	0	0	0	0	0	0	14.83	0	0	14.2	0.1	1.2
2025	10	6	12	50	30	0	0	0	0	0	0	0	14.85	0	0	14.2	0.1	1.2
2025	10	6	13	0	30	0	0	0	0	0	0	0	14.86	0	0	14.2	0.1	1.2
2025	10	6	13	10	30	0	0	0	0	0	0	0	14.87	0	0	14.2	0.1	1.2
2025	10	6	13	20	30	0	0	0	0	0	0	0	14.87	0	0	14.2	0.1	1.2
2025	10	6	13	30	30	0	0	0	0	0	0	0	14.89	0	0	14.2	0.1	1.2
2025	10	6	13	40	30	0	0	0	0	0	0	0	14.89	0	0	14.2	0.1	1.2
2025	10	6	13	50	30	0	0	0	0	0	0	0	14.9	0	0	14.2	0.1	1.2
2025	10	6	14	0	30	0	0	0	0	0	0	0	14.91	0	0	14.2	0.1	1.2
2025	10	6	14	10	30	0	0	0	0	0	0	0	14.91	0	0	14.2	0.1	1.2
2025	10	6	14	20	30	0	0	0	0	0	0	0	14.91	0	0	14.2	0.1	1.2
2025	10	6	14	30	30	0	0	0	0	0	0	0	14.92	0	0	14	0.1	1.2
2025	10	6	14	40	30	0	0	0	0	0	0	0	14.92	0	0	14.2	0.1	1.2
2025	10	6	14	50	30	0	0	0	0	0	0	0	14.92	0	0	14	0.1	1.2
2025	10	6	15	0	30	0	0	0	0	0	0	0	14.92	0	0	14	0.1	1.2
2025	10	6	15	10	30	0	0	0	0	0	0	0	14.92	0	0	14	0.1	1.2
2025	10	6	15	20	30	0	0	0	0	0	0	0	14.91	0	0	13.8	0.1	1.2
2025	10	6	15	30	30	0	0	0	0	0	0	0	14.91	0	0	13.8	0.1	1.2
2025	10	6	15	40	30	0	0	0	0	0	0	0	14.9	0	0	13.6	0.1	1.2
2025	10	6	15	50	30	0	0	0	0	0	0	0	14.89	0	0	13.6	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	6	16	0	30	0	0	0	0	0	0	0	14.89	0	0	13.4	0.1	1.2
2025	10	6	16	10	30	0	0	0	0	0	0	0	14.87	0	0	13.2	0.1	1.2
2025	10	6	16	20	30	0	0	0	0	0	0	0	14.86	0	0	13.2	0.1	1.2
2025	10	6	16	30	30	0	0	0	0	0	0	0	14.85	0	0	13	0.1	1.2
2025	10	6	16	40	30	0	0	0	0	0	0	0	14.83	0	0	12.6	0.1	1.2
2025	10	6	16	50	30	0	0	0	0	0	0	0	14.82	0	0	12.2	0.1	1.2
2025	10	6	17	0	30	0	0	0	0	0	0	0	14.81	0	0	12.2	0.1	1.2
2025	10	6	17	10	30	0	0	0	0	0	0	0	14.79	0	0	12	0.1	1.2
2025	10	6	17	20	30	0	0	0	0	0	0	0	14.77	0	0	11.8	0.1	1.2
2025	10	6	17	30	30	0	0	0	0	0	0	0	14.76	0	0	11.8	0.1	1.2
2025	10	6	17	40	30	0	0	0	0	0	0	0	14.75	0	0	11.8	0.1	1.2
2025	10	6	17	50	30	0	0	0	0	0	0	0	14.74	0	0	11.6	0.1	1.2
2025	10	6	18	0	30	0	0	0	0	0	0	0	14.72	0	0	11.6	0.1	1.2
2025	10	6	18	10	30	0	0	0	0	0	0	0	14.71	0	0	11.6	0.1	1.2
2025	10	6	18	20	30	0	0	0	0	0	0	0	14.69	0	0	11.6	0.1	1.2
2025	10	6	18	30	30	0	0	0	0	0	0	0	14.67	0	0	11.6	0.1	1.2
2025	10	6	18	40	30	0	0	0	0	0	0	0	14.65	0	0	11.6	0.1	1.2
2025	10	6	18	50	30	0	0	0	0	0	0	0	14.63	0	0	11.6	0.1	1.2
2025	10	6	19	0	30	0	0	0	0	0	0	0	14.61	0	0	11.6	0.1	1.2
2025	10	6	19	10	30	0	0	0	0	0	0	0	14.59	0	0	11.6	0.1	1.2
2025	10	6	19	20	30	0	0	0	0	0	0	0	14.57	0	0	11.6	0.1	1.2
2025	10	6	19	30	30	0	0	0	0	0	0	0	14.54	0	0	11.6	0.1	1.2
2025	10	6	19	40	30	0	0	0	0	0	0	0	14.53	0	0	11.6	0.1	1.2
2025	10	6	19	50	30	0	0	0	0	0	0	0	14.5	0	0	11.6	0.1	1.2
2025	10	6	20	0	30	0	0	0	0	0	0	0	14.48	0	0	11.6	0.1	1.2
2025	10	6	20	10	30	0	0	0	0	0	0	0	14.47	0	0	11.6	0.1	1.2
2025	10	6	20	20	30	0	0	0	0	0	0	0	14.45	0	0	11.6	0.1	1.2
2025	10	6	20	30	30	0	0	0	0	0	0	0	14.43	0	0	11.6	0.1	1.2
2025	10	6	20	40	30	0	0	0	0	0	0	0	14.41	0	0	11.6	0.1	1.2
2025	10	6	20	50	30	0	0	0	0	0	0	0	14.4	0	0	11.6	0.1	1.2
2025	10	6	21	0	30	0	0	0	0	0	0	0	14.38	0	0	11.6	0.1	1.2
2025	10	6	21	10	30	0	0	0	0	0	0	0	14.37	0	0	11.6	0.1	1.2
2025	10	6	21	20	30	0	0	0	0	0	0	0	14.36	0	0	11.6	0.1	1.2
2025	10	6	21	30	30	0	0	0	0	0	0	0	14.34	0	0	11.6	0.1	1.2
2025	10	6	21	40	30	0	0	0	0	0	0	0	14.33	0	0	11.6	0.1	1.2
2025	10	6	21	50	30	0	0	0	0	0	0	0	14.32	0	0	11.4	0.1	1.2
2025	10	6	22	0	30	0	0	0	0	0	0	0	14.31	0	0	11.4	0.1	1.2
2025	10	6	22	10	30	0	0	0	0	0	0	0	14.3	0	0	11.4	0.1	1.2
2025	10	6	22	20	30	0	0	0	0	0	0	0	14.29	0	0	11.4	0.1	1.2
2025	10	6	22	30	30	0	0	0	0	0	0	0	14.28	0	0	11.4	0.1	1.2
2025	10	6	22	40	30	0	0	0	0	0	0	0	14.27	0	0	11.4	0.1	1.2
2025	10	6	22	50	30	0	0	0	0	0	0	0	14.26	0	0	11.4	0.1	1.2
2025	10	6	23	0	30	0	0	0	0	0	0	0	14.25	0	0	11.4	0.1	1.2
2025	10	6	23	10	30	0	0	0	0	0	0	0	14.24	0	0	11.4	0.1	1.2
2025	10	6	23	20	30	0	0	0	0	0	0	0	14.24	0	0	11.4	0.1	1.2
2025	10	6	23	30	30	0	0	0	0	0	0	0	14.23	0	0	11.4	0.1	1.2
2025	10	6	23	40	30	0	0	0	0	0	0	0	14.23	0	0	11.4	0.1	1.2
2025	10	6	23	50	30	0	0	0	0	0	0	0	14.22	0	0	11.4	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	7	0	0	30	0	0	0	0	0	0	0	14.21	0	0	11.4	0.1	1.2
2025	10	7	0	10	30	0	0	0	0	0	0	0	14.21	0	0	11.4	0.1	1.2
2025	10	7	0	20	30	0	0	0	0	0	0	0	14.21	0	0	11.4	0.1	1.2
2025	10	7	0	30	30	0	0	0	0	0	0	0	14.21	0	0	11.4	0.1	1.2
2025	10	7	0	40	30	0	0	0	0	0	0	0	14.2	0	0	11.4	0.1	1.2
2025	10	7	0	50	30	0	0	0	0	0	0	0	14.2	0	0	11.4	0.1	1.2
2025	10	7	1	0	30	0	0	0	0	0	0	0	14.21	0	0	11.4	0.1	1.2
2025	10	7	1	10	30	0	0	0	0	0	0	0	14.21	0	0	11.4	0.1	1.2
2025	10	7	1	20	30	0	0	0	0	0	0	0	14.2	0	0	11.4	0.1	1.2
2025	10	7	1	30	30	0	0	0	0	0	0	0	14.2	0	0	11.4	0.1	1.2
2025	10	7	1	40	30	0	0	0	0	0	0	0	14.2	0	0	11.4	0.1	1.2
2025	10	7	1	50	30	0	0	0	0	0	0	0	14.2	0	0	11.4	0.1	1.2
2025	10	7	2	0	30	0	0	0	0	0	0	0	14.2	0	0	11.4	0.1	1.2
2025	10	7	2	10	30	0	0	0	0	0	0	0	14.21	0	0	11.4	0.1	1.2
2025	10	7	2	20	30	0	0	0	0	0	0	0	14.21	0	0	11.4	0.1	1.2
2025	10	7	2	30	30	0	0	0	0	0	0	0	14.21	0	0	11.4	0.1	1.2
2025	10	7	2	40	30	0	0	0	0	0	0	0	14.21	0	0	11.4	0.1	1.2
2025	10	7	2	50	30	0	0	0	0	0	0	0	14.21	0	0	11.4	0.1	1.2
2025	10	7	3	0	30	0	0	0	0	0	0	0	14.21	0	0	11.4	0.1	1.2
2025	10	7	3	10	30	0	0	0	0	0	0	0	14.21	0	0	11.4	0.1	1.2
2025	10	7	3	20	30	0	0	0	0	0	0	0	14.22	0	0	11.4	0.1	1.2
2025	10	7	3	30	30	0	0	0	0	0	0	0	14.21	0	0	11.4	0.1	1.2
2025	10	7	3	40	30	0	0	0	0	0	0	0	14.21	0	0	11.4	0.1	1.2
2025	10	7	3	50	30	0	0	0	0	0	0	0	14.21	0	0	11.4	0.1	1.2
2025	10	7	4	0	30	0	0	0	0	0	0	0	14.21	0	0	11.4	0.1	1.2
2025	10	7	4	10	30	0	0	0	0	0	0	0	14.2	0	0	11.4	0.1	1.2
2025	10	7	4	20	30	0	0	0	0	0	0	0	14.2	0	0	11.4	0.1	1.2
2025	10	7	4	30	30	0	0	0	0	0	0	0	14.2	0	0	11.4	0.1	1.2
2025	10	7	4	40	30	0	0	0	0	0	0	0	14.2	0	0	11.4	0.1	1.2
2025	10	7	4	50	30	0	0	0	0	0	0	0	14.19	0	0	11.4	0.1	1.2
2025	10	7	5	0	30	0	0	0	0	0	0	0	14.19	0	0	11.4	0.1	1.2
2025	10	7	5	10	30	0	0	0	0	0	0	0	14.18	0	0	11.4	0.1	1.2
2025	10	7	5	20	30	0	0	0	0	0	0	0	14.18	0	0	11.4	0.1	1.2
2025	10	7	5	30	30	0	0	0	0	0	0	0	14.17	0	0	11.4	0.1	1.2
2025	10	7	5	40	30	0	0	0	0	0	0	0	14.16	0	0	11.4	0.1	1.2
2025	10	7	5	50	30	0	0	0	0	0	0	0	14.15	0	0	11.4	0.1	1.2
2025	10	7	6	0	30	0	0	0	0	0	0	0	14.15	0	0	11.4	0.1	1.2
2025	10	7	6	10	30	0	0	0	0	0	0	0	14.14	0	0	11.4	0.1	1.2
2025	10	7	6	20	30	0	0	0	0	0	0	0	14.13	0	0	11.4	0.1	1.2
2025	10	7	6	30	30	0	0	0	0	0	0	0	14.12	0	0	11.4	0.1	1.2
2025	10	7	6	40	30	0	0	0	0	0	0	0	14.11	0	0	11.4	0.1	1.2
2025	10	7	6	50	30	0	0	0	0	0	0	0	14.1	0	0	11.4	0.1	1.2
2025	10	7	7	0	30	0	0	0	0	0	0	0	14.09	0	0	11.4	0.1	1.2
2025	10	7	7	10	30	0	0	0	0	0	0	0	14.08	0	0	11.4	0.1	1.2
2025	10	7	7	20	30	0	0	0	0	0	0	0	14.07	0	0	11.4	0.1	1.2
2025	10	7	7	30	30	0	0	0	0	0	0	0	14.06	0	0	11.4	0.1	1.2
2025	10	7	7	40	30	0	0	0	0	0	0	0	14.05	0	0	11.6	0.1	1.2
2025	10	7	7	50	30	0	0	0	0	0	0	0	14.04	0	0	11.8	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	7	8	0	30	0	0	0	0	0	0	0	14.03	0	0	12	0.1	1.2
2025	10	7	8	10	30	0	0	0	0	0	0	0	14.02	0	0	12.2	0.1	1.2
2025	10	7	8	20	30	0	0	0	0	0	0	0	14.02	0	0	12.4	0.1	1.2
2025	10	7	8	30	30	0	0	0	0	0	0	0	14.02	0	0	12.4	0.1	1.2
2025	10	7	8	40	30	0	0	0	0	0	0	0	14.02	0	0	12.4	0.1	1.2
2025	10	7	8	50	30	0	0	0	0	0	0	0	14.04	0	0	12.4	0.1	1.2
2025	10	7	9	0	30	0	0	0	0	0	0	0	14.06	0	0	12.6	0.1	1.2
2025	10	7	9	10	30	0	0	0	0	0	0	0	14.08	0	0	12.6	0.1	1.2
2025	10	7	9	20	30	0	0	0	0	0	0	0	14.09	0	0	12.8	0.1	1.2
2025	10	7	9	30	30	0	0	0	0	0	0	0	14.11	0	0	13.6	0.1	1.2
2025	10	7	9	40	30	0	0	0	0	0	0	0	14.13	0	0	14.2	0.1	1.2
2025	10	7	9	50	30	0	0	0	0	0	0	0	14.14	0	0	14.2	0.1	1.2
2025	10	7	10	0	30	0	0	0	0	0	0	0	14.15	0	0	14.2	0.1	1.2
2025	10	7	10	10	30	0	0	0	0	0	0	0	14.17	0	0	14.2	0.1	1.2
2025	10	7	10	20	30	0	0	0	0	0	0	0	14.19	0	0	14.2	0.1	1.2
2025	10	7	10	30	30	0	0	0	0	0	0	0	14.21	0	0	14.2	0.1	1.2
2025	10	7	10	40	30	0	0	0	0	0	0	0	14.22	0	0	14.2	0.1	1.2
2025	10	7	10	50	30	0	0	0	0	0	0	0	14.24	0	0	14.2	0.1	1.2
2025	10	7	11	0	30	0	0	0	0	0	0	0	14.26	0	0	14.2	0.1	1.2
2025	10	7	11	10	30	0	0	0	0	0	0	0	14.28	0	0	14.2	0.1	1.2
2025	10	7	11	20	30	0	0	0	0	0	0	0	14.3	0	0	14.2	0.1	1.2
2025	10	7	11	30	30	0	0	0	0	0	0	0	14.32	0	0	14.2	0.1	1.2
2025	10	7	11	40	30	0	0	0	0	0	0	0	14.34	0	0	14.2	0.1	1.2
2025	10	7	11	50	30	0	0	0	0	0	0	0	14.35	0	0	14.2	0.1	1.2
2025	10	7	12	0	30	0	0	0	0	0	0	0	14.38	0	0	14.2	0.1	1.2
2025	10	7	12	10	30	0	0	0	0	0	0	0	14.4	0	0	14.2	0.1	1.2
2025	10	7	12	20	30	0	0	0	0	0	0	0	14.41	0	0	14.2	0.1	1.2
2025	10	7	12	30	30	0	0	0	0	0	0	0	14.42	0	0	14.2	0.1	1.2
2025	10	7	12	40	30	0	0	0	0	0	0	0	14.44	0	0	14.2	0.1	1.2
2025	10	7	12	50	30	0	0	0	0	0	0	0	14.46	0	0	14.2	0.1	1.2
2025	10	7	13	0	30	0	0	0	0	0	0	0	14.47	0	0	14.2	0.1	1.2
2025	10	7	13	10	30	0	0	0	0	0	0	0	14.48	0	0	14.2	0.1	1.2
2025	10	7	13	20	30	0	0	0	0	0	0	0	14.49	0	0	14.2	0.1	1.2
2025	10	7	13	30	30	0	0	0	0	0	0	0	14.51	0	0	14	0.1	1.2
2025	10	7	13	40	30	0	0	0	0	0	0	0	14.53	0	0	14	0.1	1.2
2025	10	7	13	50	30	0	0	0	0	0	0	0	14.53	0	0	14	0.1	1.2
2025	10	7	14	0	30	0	0	0	0	0	0	0	14.54	0	0	14	0.1	1.2
2025	10	7	14	10	30	0	0	0	0	0	0	0	14.54	0	0	14	0.1	1.2
2025	10	7	14	20	30	0	0	0	0	0	0	0	14.54	0	0	14	0.1	1.2
2025	10	7	14	30	30	0	0	0	0	0	0	0	14.54	0	0	13.8	0.1	1.2
2025	10	7	14	40	30	0	0	0	0	0	0	0	14.55	0	0	13.8	0.1	1.2
2025	10	7	14	50	30	0	0	0	0	0	0	0	14.54	0	0	13.8	0.1	1.2
2025	10	7	15	0	30	0	0	0	0	0	0	0	14.54	0	0	13.8	0.1	1.2
2025	10	7	15	10	30	0	0	0	0	0	0	0	14.54	0	0	13.8	0.1	1.2
2025	10	7	15	20	30	0	0	0	0	0	0	0	14.54	0	0	13.6	0.1	1.2
2025	10	7	15	30	30	0	0	0	0	0	0	0	14.53	0	0	13.4	0.1	1.2
2025	10	7	15	40	30	0	0	0	0	0	0	0	14.52	0	0	13.4	0.1	1.2
2025	10	7	15	50	30	0	0	0	0	0	0	0	14.52	0	0	13.4	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	7	16	0	30	0	0	0	0	0	0	0	14.51	0	0	13.2	0.1	1.2
2025	10	7	16	10	30	0	0	0	0	0	0	0	14.5	0	0	13.2	0.1	1.2
2025	10	7	16	20	30	0	0	0	0	0	0	0	14.49	0	0	13.4	0.1	1.2
2025	10	7	16	30	30	0	0	0	0	0	0	0	14.47	0	0	13	0.1	1.2
2025	10	7	16	40	30	0	0	0	0	0	0	0	14.46	0	0	12.6	0.1	1.2
2025	10	7	16	50	30	0	0	0	0	0	0	0	14.45	0	0	12.4	0.1	1.2
2025	10	7	17	0	30	0	0	0	0	0	0	0	14.43	0	0	12	0.1	1.2
2025	10	7	17	10	30	0	0	0	0	0	0	0	14.41	0	0	11.6	0.1	1.2
2025	10	7	17	20	30	0	0	0	0	0	0	0	14.39	0	0	11.4	0.1	1.2
2025	10	7	17	30	30	0	0	0	0	0	0	0	14.38	0	0	11.6	0.1	1.2
2025	10	7	17	40	30	0	0	0	0	0	0	0	14.37	0	0	11.6	0.1	1.2
2025	10	7	17	50	30	0	0	0	0	0	0	0	14.36	0	0	11.6	0.1	1.2
2025	10	7	18	0	30	0	0	0	0	0	0	0	14.34	0	0	11	0.1	1.2
2025	10	7	18	10	30	0	0	0	0	0	0	0	14.33	0	0	11.4	0.1	1.2
2025	10	7	18	20	30	0	0	0	0	0	0	0	14.31	0	0	10.6	0.1	1.2
2025	10	7	18	30	30	0	0	0	0	0	0	0	14.29	0	0	11.4	0.1	1.2
2025	10	7	18	40	30	0	0	0	0	0	0	0	14.27	0	0	11.4	0.1	1.2
2025	10	7	18	50	30	0	0	0	0	0	0	0	14.25	0	0	11.4	0.1	1.2
2025	10	7	19	0	30	0	0	0	0	0	0	0	14.23	0	0	11.4	0.1	1.2
2025	10	7	19	10	30	0	0	0	0	0	0	0	14.21	0	0	11.4	0.1	1.2
2025	10	7	19	20	30	0	0	0	0	0	0	0	14.18	0	0	11.4	0.1	1.2
2025	10	7	19	30	30	0	0	0	0	0	0	0	14.17	0	0	11.4	0.1	1.2
2025	10	7	19	40	30	0	0	0	0	0	0	0	14.15	0	0	11.4	0.1	1.2
2025	10	7	19	50	30	0	0	0	0	0	0	0	14.13	0	0	11.4	0.1	1.2
2025	10	7	20	0	30	0	0	0	0	0	0	0	14.11	0	0	11.4	0.1	1.2
2025	10	7	20	10	30	0	0	0	0	0	0	0	14.09	0	0	11.4	0.1	1.2
2025	10	7	20	20	30	0	0	0	0	0	0	0	14.08	0	0	11.4	0.1	1.2
2025	10	7	20	30	30	0	0	0	0	0	0	0	14.06	0	0	11.4	0.1	1.2
2025	10	7	20	40	30	0	0	0	0	0	0	0	14.04	0	0	11.4	0.1	1.2
2025	10	7	20	50	30	0	0	0	0	0	0	0	14.03	0	0	11.4	0.1	1.2
2025	10	7	21	0	30	0	0	0	0	0	0	0	14.03	0	0	11.4	0.1	1.2
2025	10	7	21	10	30	0	0	0	0	0	0	0	14.01	0	0	11.4	0.1	1.2
2025	10	7	21	20	30	0	0	0	0	0	0	0	14	0	0	11.4	0.1	1.2
2025	10	7	21	30	30	0	0	0	0	0	0	0	13.99	0	0	11.4	0.1	1.2
2025	10	7	21	40	30	0	0	0	0	0	0	0	13.98	0	0	11.4	0.1	1.2
2025	10	7	21	50	30	0	0	0	0	0	0	0	13.97	0	0	11.4	0.1	1.2
2025	10	7	22	0	30	0	0	0	0	0	0	0	13.97	0	0	11.4	0.1	1.2
2025	10	7	22	10	30	0	0	0	0	0	0	0	13.95	0	0	11.4	0.1	1.2
2025	10	7	22	20	30	0	0	0	0	0	0	0	13.95	0	0	11.4	0.1	1.2
2025	10	7	22	30	30	0	0	0	0	0	0	0	13.94	0	0	11.4	0.1	1.2
2025	10	7	22	40	30	0	0	0	0	0	0	0	13.94	0	0	11.4	0.1	1.2
2025	10	7	22	50	30	0	0	0	0	0	0	0	13.93	0	0	11.4	0.1	1.2
2025	10	7	23	0	30	0	0	0	0	0	0	0	13.92	0	0	11.4	0.1	1.2
2025	10	7	23	10	30	0	0	0	0	0	0	0	13.92	0	0	11.4	0.1	1.2
2025	10	7	23	20	30	0	0	0	0	0	0	0	13.91	0	0	11.4	0.1	1.2
2025	10	7	23	30	30	0	0	0	0	0	0	0	13.9	0	0	11.4	0.1	1.2
2025	10	7	23	40	30	0	0	0	0	0	0	0	13.89	0	0	11.4	0.1	1.2
2025	10	7	23	50	30	0	0	0	0	0	0	0	13.89	0	0	11.2	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	8	0	0	30	0	0	0	0	0	0	0	13.88	0	0	11.2	0.1	1.2
2025	10	8	0	10	30	0	0	0	0	0	0	0	13.88	0	0	11.4	0.1	1.2
2025	10	8	0	20	30	0	0	0	0	0	0	0	13.88	0	0	11.4	0.1	1.2
2025	10	8	0	30	30	0	0	0	0	0	0	0	13.87	0	0	11.4	0.1	1.2
2025	10	8	0	40	30	0	0	0	0	0	0	0	13.86	0	0	11.4	0.1	1.2
2025	10	8	0	50	30	0	0	0	0	0	0	0	13.86	0	0	11.4	0.1	1.2
2025	10	8	1	0	30	0	0	0	0	0	0	0	13.86	0	0	11.4	0.1	1.2
2025	10	8	1	10	30	0	0	0	0	0	0	0	13.85	0	0	11.4	0.1	1.2
2025	10	8	1	20	30	0	0	0	0	0	0	0	13.85	0	0	11.4	0.1	1.2
2025	10	8	1	30	30	0	0	0	0	0	0	0	13.85	0	0	11.4	0.1	1.2
2025	10	8	1	40	30	0	0	0	0	0	0	0	13.85	0	0	11.4	0.1	1.2
2025	10	8	1	50	30	0	0	0	0	0	0	0	13.85	0	0	11.4	0.1	1.2
2025	10	8	2	0	30	0	0	0	0	0	0	0	13.85	0	0	11.4	0.1	1.2
2025	10	8	2	10	30	0	0	0	0	0	0	0	13.85	0	0	11.4	0.1	1.2
2025	10	8	2	20	30	0	0	0	0	0	0	0	13.85	0	0	11.4	0.1	1.2
2025	10	8	2	30	30	0	0	0	0	0	0	0	13.85	0	0	11.4	0.1	1.2
2025	10	8	2	40	30	0	0	0	0	0	0	0	13.85	0	0	11.4	0.1	1.2
2025	10	8	2	50	30	0	0	0	0	0	0	0	13.85	0	0	11.4	0.1	1.2
2025	10	8	3	0	30	0	0	0	0	0	0	0	13.84	0	0	11.4	0.1	1.2
2025	10	8	3	10	30	0	0	0	0	0	0	0	13.85	0	0	11.4	0.1	1.2
2025	10	8	3	20	30	0	0	0	0	0	0	0	13.85	0	0	11.4	0.1	1.2
2025	10	8	3	30	30	0	0	0	0	0	0	0	13.84	0	0	11.4	0.1	1.2
2025	10	8	3	40	30	0	0	0	0	0	0	0	13.84	0	0	11.4	0.1	1.2
2025	10	8	3	50	30	0	0	0	0	0	0	0	13.84	0	0	11.4	0.1	1.2
2025	10	8	4	0	30	0	0	0	0	0	0	0	13.84	0	0	11.4	0.1	1.2
2025	10	8	4	10	30	0	0	0	0	0	0	0	13.84	0	0	11.4	0.1	1.2
2025	10	8	4	20	30	0	0	0	0	0	0	0	13.84	0	0	11.4	0.1	1.2
2025	10	8	4	30	30	0	0	0	0	0	0	0	13.83	0	0	11.4	0.1	1.2
2025	10	8	4	40	30	0	0	0	0	0	0	0	13.83	0	0	11.4	0.1	1.2
2025	10	8	4	50	30	0	0	0	0	0	0	0	13.82	0	0	11.4	0.1	1.2
2025	10	8	5	0	30	0	0	0	0	0	0	0	13.81	0	0	11.4	0.1	1.2
2025	10	8	5	10	30	0	0	0	0	0	0	0	13.81	0	0	11.4	0.1	1.2
2025	10	8	5	20	30	0	0	0	0	0	0	0	13.8	0	0	11.4	0.1	1.2
2025	10	8	5	30	30	0	0	0	0	0	0	0	13.8	0	0	11.4	0.1	1.2
2025	10	8	5	40	30	0	0	0	0	0	0	0	13.79	0	0	11.4	0.1	1.2
2025	10	8	5	50	30	0	0	0	0	0	0	0	13.78	0	0	11.4	0.1	1.2
2025	10	8	6	0	30	0	0	0	0	0	0	0	13.77	0	0	11.4	0.1	1.2
2025	10	8	6	10	30	0	0	0	0	0	0	0	13.76	0	0	11.4	0.1	1.2
2025	10	8	6	20	30	0	0	0	0	0	0	0	13.75	0	0	11.4	0.1	1.2
2025	10	8	6	30	30	0	0	0	0	0	0	0	13.74	0	0	11.4	0.1	1.2
2025	10	8	6	40	30	0	0	0	0	0	0	0	13.72	0	0	11.4	0.1	1.2
2025	10	8	6	50	30	0	0	0	0	0	0	0	13.71	0	0	11.4	0.1	1.2
2025	10	8	7	0	30	0	0	0	0	0	0	0	13.7	0	0	11.4	0.1	1.2
2025	10	8	7	10	30	0	0	0	0	0	0	0	13.69	0	0	11.4	0.1	1.2
2025	10	8	7	20	30	0	0	0	0	0	0	0	13.68	0	0	11.4	0.1	1.2
2025	10	8	7	30	30	0	0	0	0	0	0	0	13.66	0	0	11.4	0.1	1.2
2025	10	8	7	40	30	0	0	0	0	0	0	0	13.65	0	0	11.6	0.1	1.2
2025	10	8	7	50	30	0	0	0	0	0	0	0	13.64	0	0	11.8	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	8	8	0	30	0	0	0	0	0	0	0	13.63	0	0	12.2	0.1	1.2
2025	10	8	8	10	30	0	0	0	0	0	0	0	13.63	0	0	12.4	0.1	1.2
2025	10	8	8	20	30	0	0	0	0	0	0	0	13.62	0	0	12.4	0.1	1.2
2025	10	8	8	30	30	0	0	0	0	0	0	0	13.62	0	0	12.6	0.1	1.2
2025	10	8	8	40	30	0	0	0	0	0	0	0	13.62	0	0	12.6	0.1	1.2
2025	10	8	8	50	30	0	0	0	0	0	0	0	13.64	0	0	12.6	0.1	1.2
2025	10	8	9	0	30	0	0	0	0	0	0	0	13.67	0	0	12.6	0.1	1.2
2025	10	8	9	10	30	0	0	0	0	0	0	0	13.69	0	0	12.8	0.1	1.2
2025	10	8	9	20	30	0	0	0	0	0	0	0	13.7	0	0	14.2	0.1	1.2
2025	10	8	9	30	30	0	0	0	0	0	0	0	13.72	0	0	14.2	0.1	1.2
2025	10	8	9	40	30	0	0	0	0	0	0	0	13.73	0	0	14.2	0.1	1.2
2025	10	8	9	50	30	0	0	0	0	0	0	0	13.74	0	0	14.2	0.1	1.2
2025	10	8	10	0	30	0	0	0	0	0	0	0	13.76	0	0	14.2	0.1	1.2
2025	10	8	10	10	30	0	0	0	0	0	0	0	13.78	0	0	14.2	0.1	1.2
2025	10	8	10	20	30	0	0	0	0	0	0	0	13.79	0	0	14.2	0.1	1.2
2025	10	8	10	30	30	0	0	0	0	0	0	0	13.82	0	0	14.2	0.1	1.2
2025	10	8	10	40	30	0	0	0	0	0	0	0	13.83	0	0	14.2	0.1	1.2
2025	10	8	10	50	30	0	0	0	0	0	0	0	13.85	0	0	14.2	0.1	1.2
2025	10	8	11	0	30	0	0	0	0	0	0	0	13.87	0	0	14.2	0.1	1.2
2025	10	8	11	10	30	0	0	0	0	0	0	0	13.89	0	0	14.2	0.1	1.2
2025	10	8	11	20	30	0	0	0	0	0	0	0	13.91	0	0	14.2	0.1	1.2
2025	10	8	11	30	30	0	0	0	0	0	0	0	13.94	0	0	14.2	0.1	1.2
2025	10	8	11	40	30	0	0	0	0	0	0	0	13.96	0	0	14.2	0.1	1.2
2025	10	8	11	50	30	0	0	0	0	0	0	0	13.98	0	0	14.2	0.1	1.2
2025	10	8	12	0	30	0	0	0	0	0	0	0	14	0	0	14.2	0.1	1.2
2025	10	8	12	10	30	0	0	0	0	0	0	0	14.02	0	0	14.2	0.1	1.2
2025	10	8	12	20	30	0	0	0	0	0	0	0	14.04	0	0	14.2	0.1	1.2
2025	10	8	12	30	30	0	0	0	0	0	0	0	14.06	0	0	13.4	0.1	1.2
2025	10	8	12	40	30	0	0	0	0	0	0	0	14.08	0	0	13.4	0.1	1.2
2025	10	8	12	50	30	0	0	0	0	0	0	0	14.09	0	0	13.6	0.1	1.2
2025	10	8	13	0	30	0	0	0	0	0	0	0	14.1	0	0	13.6	0.1	1.2
2025	10	8	13	10	30	0	0	0	0	0	0	0	14.11	0	0	13.6	0.1	1.2
2025	10	8	13	20	30	0	0	0	0	0	0	0	14.12	0	0	13.6	0.1	1.2
2025	10	8	13	30	30	0	0	0	0	0	0	0	14.13	0	0	13.6	0.1	1.2
2025	10	8	13	40	30	0	0	0	0	0	0	0	14.14	0	0	13.6	0.1	1.2
2025	10	8	13	50	30	0	0	0	0	0	0	0	14.14	0	0	13.6	0.1	1.2
2025	10	8	14	0	30	0	0	0	0	0	0	0	14.14	0	0	13.4	0.1	1.2
2025	10	8	14	10	30	0	0	0	0	0	0	0	14.15	0	0	13.4	0.1	1.2
2025	10	8	14	20	30	0	0	0	0	0	0	0	14.15	0	0	13.6	0.1	1.2
2025	10	8	14	30	30	0	0	0	0	0	0	0	14.14	0	0	13.4	0.1	1.2
2025	10	8	14	40	30	0	0	0	0	0	0	0	14.15	0	0	13.6	0.1	1.2
2025	10	8	14	50	30	0	0	0	0	0	0	0	14.15	0	0	13.6	0.1	1.2
2025	10	8	15	0	30	0	0	0	0	0	0	0	14.15	0	0	13.6	0.1	1.2
2025	10	8	15	10	30	0	0	0	0	0	0	0	14.14	0	0	13.6	0.1	1.2
2025	10	8	15	20	30	0	0	0	0	0	0	0	14.13	0	0	13.6	0.1	1.2
2025	10	8	15	30	30	0	0	0	0	0	0	0	14.12	0	0	13.6	0.1	1.2
2025	10	8	15	40	30	0	0	0	0	0	0	0	14.12	0	0	13.6	0.1	1.2
2025	10	8	15	50	30	0	0	0	0	0	0	0	14.11	0	0	13.6	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	8	16	0	30	0	0	0	0	0	0	0	14.1	0	0	13.4	0.1	1.2
2025	10	8	16	10	30	0	0	0	0	0	0	0	14.09	0	0	13.4	0.1	1.2
2025	10	8	16	20	30	0	0	0	0	0	0	0	14.07	0	0	13.2	0.1	1.2
2025	10	8	16	30	30	0	0	0	0	0	0	0	14.06	0	0	12.8	0.1	1.2
2025	10	8	16	40	30	0	0	0	0	0	0	0	14.04	0	0	12.4	0.1	1.2
2025	10	8	16	50	30	0	0	0	0	0	0	0	14.03	0	0	12.4	0.1	1.2
2025	10	8	17	0	30	0	0	0	0	0	0	0	14.01	0	0	12.2	0.1	1.2
2025	10	8	17	10	30	0	0	0	0	0	0	0	13.99	0	0	12.2	0.1	1.2
2025	10	8	17	20	30	0	0	0	0	0	0	0	13.98	0	0	12	0.1	1.2
2025	10	8	17	30	30	0	0	0	0	0	0	0	13.96	0	0	11.8	0.1	1.2
2025	10	8	17	40	30	0	0	0	0	0	0	0	13.95	0	0	11.8	0.1	1.2
2025	10	8	17	50	30	0	0	0	0	0	0	0	13.93	0	0	11.8	0.1	1.2
2025	10	8	18	0	30	0	0	0	0	0	0	0	13.91	0	0	11.8	0.1	1.2
2025	10	8	18	10	30	0	0	0	0	0	0	0	13.89	0	0	11.8	0.1	1.2
2025	10	8	18	20	30	0	0	0	0	0	0	0	13.87	0	0	11.8	0.1	1.2
2025	10	8	18	30	30	0	0	0	0	0	0	0	13.85	0	0	11.8	0.1	1.2
2025	10	8	18	40	30	0	0	0	0	0	0	0	13.83	0	0	11.8	0.1	1.2
2025	10	8	18	50	30	0	0	0	0	0	0	0	13.82	0	0	11.8	0.1	1.2
2025	10	8	19	0	30	0	0	0	0	0	0	0	13.8	0	0	11.8	0.1	1.2
2025	10	8	19	10	30	0	0	0	0	0	0	0	13.78	0	0	11.8	0.1	1.2
2025	10	8	19	20	30	0	0	0	0	0	0	0	13.77	0	0	11.8	0.1	1.2
2025	10	8	19	30	30	0	0	0	0	0	0	0	13.75	0	0	11.8	0.1	1.2
2025	10	8	19	40	30	0	0	0	0	0	0	0	13.73	0	0	11.8	0.1	1.2
2025	10	8	19	50	30	0	0	0	0	0	0	0	13.72	0	0	11.8	0.1	1.2
2025	10	8	20	0	30	0	0	0	0	0	0	0	13.71	0	0	11.8	0.1	1.2
2025	10	8	20	10	30	0	0	0	0	0	0	0	13.7	0	0	11.8	0.1	1.2
2025	10	8	20	20	30	0	0	0	0	0	0	0	13.69	0	0	11.6	0.1	1.2
2025	10	8	20	30	30	0	0	0	0	0	0	0	13.67	0	0	11.6	0.1	1.2
2025	10	8	20	40	30	0	0	0	0	0	0	0	13.67	0	0	11.6	0.1	1.2
2025	10	8	20	50	30	0	0	0	0	0	0	0	13.65	0	0	11.6	0.1	1.2
2025	10	8	21	0	30	0	0	0	0	0	0	0	13.65	0	0	11.6	0.1	1.2
2025	10	8	21	10	30	0	0	0	0	0	0	0	13.64	0	0	11.6	0.1	1.2
2025	10	8	21	20	30	0	0	0	0	0	0	0	13.64	0	0	11.6	0.1	1.2
2025	10	8	21	30	30	0	0	0	0	0	0	0	13.63	0	0	11.6	0.1	1.2
2025	10	8	21	40	30	0	0	0	0	0	0	0	13.63	0	0	11.6	0.1	1.2
2025	10	8	21	50	30	0	0	0	0	0	0	0	13.62	0	0	11.6	0.1	1.2
2025	10	8	22	0	30	0	0	0	0	0	0	0	13.62	0	0	11.6	0.1	1.2
2025	10	8	22	10	30	0	0	0	0	0	0	0	13.62	0	0	11.6	0.1	1.2
2025	10	8	22	20	30	0	0	0	0	0	0	0	13.62	0	0	11.6	0.1	1.2
2025	10	8	22	30	30	0	0	0	0	0	0	0	13.62	0	0	11.6	0.1	1.2
2025	10	8	22	40	30	0	0	0	0	0	0	0	13.62	0	0	11.6	0.1	1.2
2025	10	8	22	50	30	0	0	0	0	0	0	0	13.63	0	0	11.6	0.1	1.2
2025	10	8	23	0	30	0	0	0	0	0	0	0	13.63	0	0	11.6	0.1	1.2
2025	10	8	23	10	30	0	0	0	0	0	0	0	13.63	0	0	11.6	0.1	1.2
2025	10	8	23	20	30	0	0	0	0	0	0	0	13.64	0	0	11.6	0.1	1.2
2025	10	8	23	30	30	0	0	0	0	0	0	0	13.64	0	0	11.6	0.1	1.2
2025	10	8	23	40	30	0	0	0	0	0	0	0	13.65	0	0	11.6	0.1	1.2
2025	10	8	23	50	30	0	0	0	0	0	0	0	13.66	0	0	11.6	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	9	0	0	30	0	0	0	0	0	0	0	13.67	0	0	11.6	0.1	1.2
2025	10	9	0	10	30	0	0	0	0	0	0	0	13.68	0	0	11.6	0.1	1.2
2025	10	9	0	20	30	0	0	0	0	0	0	0	13.68	0	0	11.6	0.1	1.2
2025	10	9	0	30	30	0	0	0	0	0	0	0	13.69	0	0	11.6	0.1	1.2
2025	10	9	0	40	30	0	0	0	0	0	0	0	13.7	0	0	11.6	0.1	1.2
2025	10	9	0	50	30	0	0	0	0	0	0	0	13.71	0	0	11.6	0.1	1.2
2025	10	9	1	0	30	0	0	0	0	0	0	0	13.72	0	0	11.6	0.1	1.2
2025	10	9	1	10	30	0	0	0	0	0	0	0	13.73	0	0	11.6	0.1	1.2
2025	10	9	1	20	30	0	0	0	0	0	0	0	13.74	0	0	11.6	0.1	1.2
2025	10	9	1	30	30	0	0	0	0	0	0	0	13.75	0	0	11.6	0.1	1.2
2025	10	9	1	40	30	0	0	0	0	0	0	0	13.76	0	0	11.6	0.1	1.2
2025	10	9	1	50	30	0	0	0	0	0	0	0	13.77	0	0	11.6	0.1	1.2
2025	10	9	2	0	30	0	0	0	0	0	0	0	13.78	0	0	11.6	0.1	1.2
2025	10	9	2	10	30	0	0	0	0	0	0	0	13.79	0	0	11.6	0.1	1.2
2025	10	9	2	20	30	0	0	0	0	0	0	0	13.8	0	0	11.6	0.1	1.2
2025	10	9	2	30	30	0	0	0	0	0	0	0	13.8	0	0	11.6	0.1	1.2
2025	10	9	2	40	30	0	0	0	0	0	0	0	13.81	0	0	11.6	0.1	1.2
2025	10	9	2	50	30	0	0	0	0	0	0	0	13.82	0	0	11.6	0.1	1.2
2025	10	9	3	0	30	0	0	0	0	0	0	0	13.82	0	0	11.6	0.1	1.2
2025	10	9	3	10	30	0	0	0	0	0	0	0	13.83	0	0	11.6	0.1	1.2
2025	10	9	3	20	30	0	0	0	0	0	0	0	13.84	0	0	11.6	0.1	1.2
2025	10	9	3	30	30	0	0	0	0	0	0	0	13.84	0	0	11.6	0.1	1.2
2025	10	9	3	40	30	0	0	0	0	0	0	0	13.85	0	0	11.6	0.1	1.2
2025	10	9	3	50	30	0	0	0	0	0	0	0	13.86	0	0	11.6	0.1	1.2
2025	10	9	4	0	30	0	0	0	0	0	0	0	13.86	0	0	11.6	0.1	1.2
2025	10	9	4	10	30	0	0	0	0	0	0	0	13.86	0	0	11.6	0.1	1.2
2025	10	9	4	20	30	0	0	0	0	0	0	0	13.87	0	0	11.6	0.1	1.2
2025	10	9	4	30	30	0	0	0	0	0	0	0	13.86	0	0	11.6	0.1	1.2
2025	10	9	4	40	30	0	0	0	0	0	0	0	13.87	0	0	11.6	0.1	1.2
2025	10	9	4	50	30	0	0	0	0	0	0	0	13.87	0	0	11.6	0.1	1.2
2025	10	9	5	0	30	0	0	0	0	0	0	0	13.87	0	0	11.6	0.1	1.2
2025	10	9	5	10	30	0	0	0	0	0	0	0	13.88	0	0	11.6	0.1	1.2
2025	10	9	5	20	30	0	0	0	0	0	0	0	13.88	0	0	11.6	0.1	1.2
2025	10	9	5	30	30	0	0	0	0	0	0	0	13.88	0	0	11.6	0.1	1.2
2025	10	9	5	40	30	0	0	0	0	0	0	0	13.89	0	0	11.6	0.1	1.2
2025	10	9	5	50	30	0	0	0	0	0	0	0	13.88	0	0	11.6	0.1	1.2
2025	10	9	6	0	30	0	0	0	0	0	0	0	13.88	0	0	11.6	0.1	1.2
2025	10	9	6	10	30	0	0	0	0	0	0	0	13.87	0	0	11.6	0.1	1.2
2025	10	9	6	20	30	0	0	0	0	0	0	0	13.87	0	0	11.6	0.1	1.2
2025	10	9	6	30	30	0	0	0	0	0	0	0	13.87	0	0	11.6	0.1	1.2
2025	10	9	6	40	30	0	0	0	0	0	0	0	13.86	0	0	11.6	0.1	1.2
2025	10	9	6	50	30	0	0	0	0	0	0	0	13.85	0	0	11.6	0.1	1.2
2025	10	9	7	0	30	0	0	0	0	0	0	0	13.85	0	0	11.6	0.1	1.2
2025	10	9	7	10	30	0	0	0	0	0	0	0	13.84	0	0	11.6	0.1	1.2
2025	10	9	7	20	30	0	0	0	0	0	0	0	13.85	0	0	11.6	0.1	1.2
2025	10	9	7	30	30	0	0	0	0	0	0	0	13.83	0	0	11.6	0.1	1.2
2025	10	9	7	40	30	0	0	0	0	0	0	0	13.83	0	0	11.8	0.1	1.2
2025	10	9	7	50	30	0	0	0	0	0	0	0	13.83	0	0	11.8	0.1	1.2

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	9	8	0	30	0	0	0	0	0	0	0	13.83	0	0	12	0.1	1.2
2025	10	9	8	10	30	0	0	0	0	0	0	0	13.82	0	0	12.2	0.1	1.2
2025	10	9	8	20	30	0	0	0	0	0	0	0	13.82	0	0	12.2	0.1	1.2
2025	10	9	8	30	30	0	0	0	0	0	0	0	13.82	0	0	12.4	0.1	1.2
2025	10	9	8	40	30	0	0	0	0	0	0	0	13.82	0	0	12.4	0.1	1.2
2025	10	9	8	50	30	0	0	0	0	0	0	0	13.84	0	0	12.4	0.1	1.2
2025	10	9	9	0	30	0	0	0	0	0	0	0	13.85	0	0	12.4	0.1	1.2
2025	10	9	9	10	30	0	0	0	0	0	0	0	13.85	0	0	12.4	0.1	1.2
2025	10	9	9	20	30	0	0	0	0	0	0	0	13.86	0	0	12.6	0.1	1.2
2025	10	9	9	30	30	0	0	0	0	0	0	0	13.86	0	0	12.6	0.1	1.2
2025	10	9	9	40	30	0	0	0	0	0	0	0	13.87	0	0	12.6	0.1	1.2
2025	10	9	9	50	30	0	0	0	0	0	0	0	13.89	0	0	12.8	0.1	1.2
2025	10	9	10	0	30	0	0	0	0	0	0	0	13.9	0	0	13	0.1	1.2
2025	10	9	10	10	30	0	0	0	0	0	0	0	13.91	0	0	13.4	0.1	1.2
2025	10	9	10	20	30	0	0	0	0	0	0	0	13.94	0	0	13.6	0.1	1.2
2025	10	9	10	30	30	0	0	0	0	0	0	0	13.96	0	0	13.6	0.1	1.2
2025	10	9	10	40	30	0	0	0	0	0	0	0	13.98	0	0	13.6	0.1	1.2
2025	10	9	10	50	30	0	0	0	0	0	0	0	14	0	0	13.6	0.1	1.2
2025	10	9	11	0	30	0	0	0	0	0	0	0	14.02	0	0	13.6	0.1	1.2
2025	10	9	11	10	30	0	0	0	0	0	0	0	14.05	0	0	13.6	0.1	1.2
2025	10	9	11	20	30	0	0	0	0	0	0	0	14.08	0	0	13.6	0.1	1.2
2025	10	9	11	30	30	0	0	0	0	0	0	0	14.09	0	0	13.6	0.1	1.2
2025	10	9	11	40	30	0	0	0	0	0	0	0	14.11	0	0	13.6	0.1	1.2
2025	10	9	11	50	30	0	0	0	0	0	0	0	14.13	0	0	13.6	0.1	1.2
2025	10	9	12	0	30	0	0	0	0	0	0	0	14.13	0	0	13.6	0.1	1.2
2025	10	9	12	10	30	0	0	0	0	0	0	0	14.15	0	0	13.6	0.1	1.2
2025	10	9	12	20	30	0	0	0	0	0	0	0	14.15	0	0	13.6	0.1	1.2
2025	10	9	12	30	30	0	0	0	0	0	0	0	14.16	0	0	13.6	0.1	1.2
2025	10	9	12	40	30	0	0	0	0	0	0	0	14.17	0	0	13.6	0.1	1.2
2025	10	9	12	50	30	0	0	0	0	0	0	0	14.18	0	0	13.6	0.1	1.2
2025	10	9	13	0	30	0	0	0	0	0	0	0	14.18	0	0	13.6	0.1	1.2
2025	10	9	13	10	30	0	0	0	0	0	0	0	14.19	0	0	13.6	0.1	1.2
2025	10	9	13	20	30	0	0	0	0	0	0	0	14.2	0	0	13.6	0.1	1.2
2025	10	9	13	30	30	0	0	0	0	0	0	0	14.21	0	0	13.6	0.1	1.2
2025	10	9	13	40	30	0	0	0	0	0	0	0	14.21	0	0	13.6	0.1	1.2
2025	10	9	13	50	30	0	0	0	0	0	0	0	14.21	0	0	13.6	0.1	1.2
2025	10	9	14	0	30	0	0	0	0	0	0	0	14.22	0	0	13.6	0.1	1.2
2025	10	9	14	10	30	0	0	0	0	0	0	0	14.22	0	0	13.6	0.1	1.2
2025	10	9	14	20	30	0	0	0	0	0	0	0	14.22	0	0	13.6	0.1	1.2
2025	10	9	14	30	30	0	0	0	0	0	0	0	14.23	0	0	13.6	0.1	1.2
2025	10	9	14	40	30	0	0	0	0	0	0	0	14.23	0	0	13.6	0.1	1.2
2025	10	9	14	50	30	0	0	0	0	0	0	0	14.22	0	0	13.6	0.1	1.2
2025	10	9	15	0	30	0	0	0	0	0	0	0	14.22	0	0	13.6	0.1	1.2
2025	10	9	15	10	30	0	0	0	0	0	0	0	14.22	0	0	13.6	0.1	1.2
2025	10	9	15	20	30	0	0	0	0	0	0	0	14.22	0	0	13.6	0.1	1.2
2025	10	9	15	30	30	0	0	0	0	0	0	0	14.22	0	0	13.6	0.1	1.2
2025	10	9	15	40	30	0	0	0	0	0	0	0	14.22	0	0	13.6	0.1	1.2
2025	10	9	15	50	30	0	0	0	0	0	0	0	14.21	0	0	13.6	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	9	16	0	30	0	0	0	0	0	0	0	14.21	0	0	13.6	0.1	1.2
2025	10	9	16	10	30	0	0	0	0	0	0	0	14.2	0	0	13.6	0.1	1.2
2025	10	9	16	20	30	0	0	0	0	0	0	0	14.19	0	0	13.6	0.1	1.2
2025	10	9	16	30	30	0	0	0	0	0	0	0	14.18	0	0	12.8	0.1	1.2
2025	10	9	16	40	30	0	0	0	0	0	0	0	14.18	0	0	12.6	0.1	1.2
2025	10	9	16	50	30	0	0	0	0	0	0	0	14.17	0	0	12.4	0.1	1.2
2025	10	9	17	0	30	0	0	0	0	0	0	0	14.16	0	0	12.2	0.1	1.2
2025	10	9	17	10	30	0	0	0	0	0	0	0	14.15	0	0	12.2	0.1	1.2
2025	10	9	17	20	30	0	0	0	0	0	0	0	14.14	0	0	12	0.1	1.2
2025	10	9	17	30	30	0	0	0	0	0	0	0	14.13	0	0	11.8	0.1	1.2
2025	10	9	17	40	30	0	0	0	0	0	0	0	14.12	0	0	11.8	0.1	1.2
2025	10	9	17	50	30	0	0	0	0	0	0	0	14.12	0	0	11.8	0.1	1.2
2025	10	9	18	0	30	0	0	0	0	0	0	0	14.11	0	0	11.8	0.1	1.2
2025	10	9	18	10	30	0	0	0	0	0	0	0	14.1	0	0	11.8	0.1	1.2
2025	10	9	18	20	30	0	0	0	0	0	0	0	14.09	0	0	11.8	0.1	1.2
2025	10	9	18	30	30	0	0	0	0	0	0	0	14.08	0	0	11.8	0.1	1.2
2025	10	9	18	40	30	0	0	0	0	0	0	0	14.07	0	0	11.8	0.1	1.2
2025	10	9	18	50	30	0	0	0	0	0	0	0	14.06	0	0	11.8	0.1	1.2
2025	10	9	19	0	30	0	0	0	0	0	0	0	14.06	0	0	11.8	0.1	1.2
2025	10	9	19	10	30	0	0	0	0	0	0	0	14.04	0	0	11.8	0.1	1.2
2025	10	9	19	20	30	0	0	0	0	0	0	0	14.03	0	0	11.8	0.1	1.2
2025	10	9	19	30	30	0	0	0	0	0	0	0	14.02	0	0	11.8	0.1	1.2
2025	10	9	19	40	30	0	0	0	0	0	0	0	14.02	0	0	11.8	0.1	1.2
2025	10	9	19	50	30	0	0	0	0	0	0	0	14.01	0	0	11.8	0.1	1.2
2025	10	9	20	0	30	0	0	0	0	0	0	0	14	0	0	11.8	0.1	1.2
2025	10	9	20	10	30	0	0	0	0	0	0	0	14	0	0	11.8	0.1	1.2
2025	10	9	20	20	30	0	0	0	0	0	0	0	14	0	0	11.8	0.1	1.2
2025	10	9	20	30	30	0	0	0	0	0	0	0	13.99	0	0	11.6	0.1	1.2
2025	10	9	20	40	30	0	0	0	0	0	0	0	13.98	0	0	11.6	0.1	1.2
2025	10	9	20	50	30	0	0	0	0	0	0	0	13.97	0	0	11.6	0.1	1.2
2025	10	9	21	0	30	0	0	0	0	0	0	0	13.97	0	0	11.6	0.1	1.2
2025	10	9	21	10	30	0	0	0	0	0	0	0	13.97	0	0	11.6	0.1	1.2
2025	10	9	21	20	30	0	0	0	0	0	0	0	13.96	0	0	11.6	0.1	1.2
2025	10	9	21	30	30	0	0	0	0	0	0	0	13.96	0	0	11.6	0.1	1.2
2025	10	9	21	40	30	0	0	0	0	0	0	0	13.96	0	0	11.6	0.1	1.2
2025	10	9	21	50	30	0	0	0	0	0	0	0	13.96	0	0	11.6	0.1	1.2
2025	10	9	22	0	30	0	0	0	0	0	0	0	13.96	0	0	11.6	0.1	1.2
2025	10	9	22	10	30	0	0	0	0	0	0	0	13.96	0	0	11.6	0.1	1.2
2025	10	9	22	20	30	0	0	0	0	0	0	0	13.97	0	0	11.6	0.1	1.2
2025	10	9	22	30	30	0	0	0	0	0	0	0	13.97	0	0	11.6	0.1	1.2
2025	10	9	22	40	30	0	0	0	0	0	0	0	13.98	0	0	11.6	0.1	1.2
2025	10	9	22	50	30	0	0	0	0	0	0	0	13.98	0	0	11.6	0.1	1.2
2025	10	9	23	0	30	0	0	0	0	0	0	0	14	0	0	11.6	0.1	1.2
2025	10	9	23	10	30	0	0	0	0	0	0	0	14.01	0	0	11.6	0.1	1.2
2025	10	9	23	20	30	0	0	0	0	0	0	0	14.02	0	0	11.6	0.1	1.2
2025	10	9	23	30	30	0	0	0	0	0	0	0	14.03	0	0	11.6	0.1	1.2
2025	10	9	23	40	30	0	0	0	0	0	0	0	14.04	0	0	11.6	0.1	1.2
2025	10	9	23	50	30	0	0	0	0	0	0	0	14.05	0	0	11.6	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	10	0	0	30	0	0	0	0	0	0	0	14.06	0	0	11.6	0.1	1.2
2025	10	10	0	10	30	0	0	0	0	0	0	0	14.07	0	0	11.6	0.1	1.2
2025	10	10	0	20	30	0	0	0	0	0	0	0	14.09	0	0	11.6	0.1	1.2
2025	10	10	0	30	30	0	0	0	0	0	0	0	14.09	0	0	11.6	0.1	1.2
2025	10	10	0	40	30	0	0	0	0	0	0	0	14.11	0	0	11.6	0.1	1.2
2025	10	10	0	50	30	0	0	0	0	0	0	0	14.13	0	0	11.6	0.1	1.2
2025	10	10	1	0	30	0	0	0	0	0	0	0	14.14	0	0	11.6	0.1	1.2
2025	10	10	1	10	30	0	0	0	0	0	0	0	14.15	0	0	11.6	0.1	1.2
2025	10	10	1	20	30	0	0	0	0	0	0	0	14.16	0	0	11.6	0.1	1.2
2025	10	10	1	30	30	0	0	0	0	0	0	0	14.18	0	0	11.6	0.1	1.2
2025	10	10	1	40	30	0	0	0	0	0	0	0	14.19	0	0	11.6	0.1	1.2
2025	10	10	1	50	30	0	0	0	0	0	0	0	14.21	0	0	11.6	0.1	1.2
2025	10	10	2	0	30	0	0	0	0	0	0	0	14.22	0	0	11.6	0.1	1.2
2025	10	10	2	10	30	0	0	0	0	0	0	0	14.24	0	0	11.6	0.1	1.2
2025	10	10	2	20	30	0	0	0	0	0	0	0	14.25	0	0	11.6	0.1	1.2
2025	10	10	2	30	30	0	0	0	0	0	0	0	14.26	0	0	11.6	0.1	1.2
2025	10	10	2	40	30	0	0	0	0	0	0	0	14.27	0	0	11.6	0.1	1.2
2025	10	10	2	50	30	0	0	0	0	0	0	0	14.28	0	0	11.6	0.1	1.2
2025	10	10	3	0	30	0	0	0	0	0	0	0	14.29	0	0	11.6	0.1	1.2
2025	10	10	3	10	30	0	0	0	0	0	0	0	14.31	0	0	11.6	0.1	1.2
2025	10	10	3	20	30	0	0	0	0	0	0	0	14.32	0	0	11.6	0.1	1.2
2025	10	10	3	30	30	0	0	0	0	0	0	0	14.33	0	0	11.6	0.1	1.2
2025	10	10	3	40	30	0	0	0	0	0	0	0	14.33	0	0	11.6	0.1	1.2
2025	10	10	3	50	30	0	0	0	0	0	0	0	14.34	0	0	11.6	0.1	1.2
2025	10	10	4	0	30	0	0	0	0	0	0	0	14.35	0	0	11.6	0.1	1.2
2025	10	10	4	10	30	0	0	0	0	0	0	0	14.36	0	0	11.6	0.1	1.2
2025	10	10	4	20	30	0	0	0	0	0	0	0	14.37	0	0	11.6	0.1	1.2
2025	10	10	4	30	30	0	0	0	0	0	0	0	14.37	0	0	11.6	0.1	1.2
2025	10	10	4	40	30	0	0	0	0	0	0	0	14.38	0	0	11.6	0.1	1.2
2025	10	10	4	50	30	0	0	0	0	0	0	0	14.38	0	0	11.6	0.1	1.2
2025	10	10	5	0	30	0	0	0	0	0	0	0	14.39	0	0	11.6	0.1	1.2
2025	10	10	5	10	30	0	0	0	0	0	0	0	14.39	0	0	11.6	0.1	1.2
2025	10	10	5	20	30	0	0	0	0	0	0	0	14.39	0	0	11.6	0.1	1.2
2025	10	10	5	30	30	0	0	0	0	0	0	0	14.4	0	0	11.6	0.1	1.2
2025	10	10	5	40	30	0	0	0	0	0	0	0	14.4	0	0	11.6	0.1	1.2
2025	10	10	5	50	30	0	0	0	0	0	0	0	14.41	0	0	11.6	0.1	1.2
2025	10	10	6	0	30	0	0	0	0	0	0	0	14.41	0	0	11.6	0.1	1.2
2025	10	10	6	10	30	0	0	0	0	0	0	0	14.41	0	0	11.6	0.1	1.2
2025	10	10	6	20	30	0	0	0	0	0	0	0	14.42	0	0	11.6	0.1	1.2
2025	10	10	6	30	30	0	0	0	0	0	0	0	14.42	0	0	11.6	0.1	1.2
2025	10	10	6	40	30	0	0	0	0	0	0	0	14.42	0	0	11.6	0.1	1.2
2025	10	10	6	50	30	0	0	0	0	0	0	0	14.42	0	0	11.6	0.1	1.2
2025	10	10	7	0	30	0	0	0	0	0	0	0	14.42	0	0	11.6	0.1	1.2
2025	10	10	7	10	30	0	0	0	0	0	0	0	14.43	0	0	11.6	0.1	1.2
2025	10	10	7	20	30	0	0	0	0	0	0	0	14.43	0	0	11.6	0.1	1.2
2025	10	10	7	30	30	0	0	0	0	0	0	0	14.43	0	0	11.6	0.1	1.2
2025	10	10	7	40	30	0	0	0	0	0	0	0	14.43	0	0	11.6	0.1	1.2
2025	10	10	7	50	30	0	0	0	0	0	0	0	14.43	0	0	11.8	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	10	8	0	30	0	0	0	0	0	0	0	14.43	0	0	12	0.1	1.2
2025	10	10	8	10	30	0	0	0	0	0	0	0	14.44	0	0	12.2	0.1	1.2
2025	10	10	8	20	30	0	0	0	0	0	0	0	14.45	0	0	12.2	0.1	1.2
2025	10	10	8	30	30	0	0	0	0	0	0	0	14.45	0	0	12.2	0.1	1.2
2025	10	10	8	40	30	0	0	0	0	0	0	0	14.46	0	0	12.4	0.1	1.2
2025	10	10	8	50	30	0	0	0	0	0	0	0	14.5	0	0	12.4	0.1	1.2
2025	10	10	9	0	30	0	0	0	0	0	0	0	14.52	0	0	12.4	0.1	1.2
2025	10	10	9	10	30	0	0	0	0	0	0	0	14.53	0	0	12.4	0.1	1.2
2025	10	10	9	20	30	0	0	0	0	0	0	0	14.55	0	0	12.4	0.1	1.2
2025	10	10	9	30	30	0	0	0	0	0	0	0	14.57	0	0	12.6	0.1	1.2
2025	10	10	9	40	30	0	0	0	0	0	0	0	14.59	0	0	12.6	0.1	1.2
2025	10	10	9	50	30	0	0	0	0	0	0	0	14.61	0	0	12.6	0.1	1.2
2025	10	10	10	0	30	0	0	0	0	0	0	0	14.65	0	0	12.8	0.1	1.2
2025	10	10	10	10	30	0	0	0	0	0	0	0	14.66	0	0	13.2	0.1	1.2
2025	10	10	10	20	30	0	0	0	0	0	0	0	14.68	0	0	13.6	0.1	1.2
2025	10	10	10	30	30	0	0	0	0	0	0	0	14.71	0	0	13.6	0.1	1.2
2025	10	10	10	40	30	0	0	0	0	0	0	0	14.73	0	0	13.6	0.1	1.2
2025	10	10	10	50	30	0	0	0	0	0	0	0	14.74	0	0	13.6	0.1	1.2
2025	10	10	11	0	30	0	0	0	0	0	0	0	14.78	0	0	13.6	0.1	1.2
2025	10	10	11	10	30	0	0	0	0	0	0	0	14.81	0	0	13.6	0.1	1.2
2025	10	10	11	20	30	0	0	0	0	0	0	0	14.84	0	0	13.6	0.1	1.2
2025	10	10	11	30	30	0	0	0	0	0	0	0	14.86	0	0	13.6	0.1	1.2
2025	10	10	11	40	30	0	0	0	0	0	0	0	14.88	0	0	13.6	0.1	1.2
2025	10	10	11	50	30	0	0	0	0	0	0	0	14.9	0	0	13.6	0.1	1.2
2025	10	10	12	0	30	0	0	0	0	0	0	0	14.93	0	0	13.6	0.1	1.2
2025	10	10	12	10	30	0	0	0	0	0	0	0	14.96	0	0	13.6	0.1	1.2
2025	10	10	12	20	30	0	0	0	0	0	0	0	14.98	0	0	13.6	0.1	1.2
2025	10	10	12	30	30	0	0	0	0	0	0	0	15	0	0	13.6	0.1	1.2
2025	10	10	12	40	30	0	0	0	0	0	0	0	15.02	0	0	13.6	0.1	1.2
2025	10	10	12	50	30	0	0	0	0	0	0	0	15.04	0	0	13.6	0.1	1.2
2025	10	10	13	0	30	0	0	0	0	0	0	0	15.06	0	0	13.6	0.1	1.2
2025	10	10	13	10	30	0	0	0	0	0	0	0	15.07	0	0	13.6	0.1	1.2
2025	10	10	13	20	30	0	0	0	0	0	0	0	15.09	0	0	13.6	0.1	1.2
2025	10	10	13	30	30	0	0	0	0	0	0	0	15.11	0	0	13.6	0.1	1.2
2025	10	10	13	40	30	0	0	0	0	0	0	0	15.12	0	0	13.6	0.1	1.2
2025	10	10	13	50	30	0	0	0	0	0	0	0	15.13	0	0	13.6	0.1	1.2
2025	10	10	14	0	30	0	0	0	0	0	0	0	15.15	0	0	13.6	0.1	1.2
2025	10	10	14	10	30	0	0	0	0	0	0	0	15.16	0	0	13.6	0.1	1.2
2025	10	10	14	20	30	0	0	0	0	0	0	0	15.17	0	0	13.6	0.1	1.2
2025	10	10	14	30	30	0	0	0	0	0	0	0	15.18	0	0	13.6	0.1	1.2
2025	10	10	14	40	30	0	0	0	0	0	0	0	15.19	0	0	13.6	0.1	1.2
2025	10	10	14	50	30	0	0	0	0	0	0	0	15.19	0	0	13.6	0.1	1.2
2025	10	10	15	0	30	0	0	0	0	0	0	0	15.2	0	0	13.6	0.1	1.2
2025	10	10	15	10	30	0	0	0	0	0	0	0	15.21	0	0	13.6	0.1	1.2
2025	10	10	15	20	30	0	0	0	0	0	0	0	15.22	0	0	13.6	0.1	1.2
2025	10	10	15	30	30	0	0	0	0	0	0	0	15.22	0	0	13.6	0.1	1.2
2025	10	10	15	40	30	0	0	0	0	0	0	0	15.23	0	0	13.4	0.1	1.2
2025	10	10	15	50	30	0	0	0	0	0	0	0	15.23	0	0	13.6	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	10	16	0	30	0	0	0	0	0	0	0	15.24	0	0	13.6	0.1	1.2
2025	10	10	16	10	30	0	0	0	0	0	0	0	15.24	0	0	13.6	0.1	1.2
2025	10	10	16	20	30	0	0	0	0	0	0	0	15.24	0	0	13.2	0.1	1.2
2025	10	10	16	30	30	0	0	0	0	0	0	0	15.24	0	0	12.6	0.1	1.2
2025	10	10	16	40	30	0	0	0	0	0	0	0	15.23	0	0	12.4	0.1	1.2
2025	10	10	16	50	30	0	0	0	0	0	0	0	15.24	0	0	12.4	0.1	1.2
2025	10	10	17	0	30	0	0	0	0	0	0	0	15.22	0	0	12.2	0.1	1.2
2025	10	10	17	10	30	0	0	0	0	0	0	0	15.22	0	0	12	0.1	1.2
2025	10	10	17	20	30	0	0	0	0	0	0	0	15.21	0	0	12	0.1	1.2
2025	10	10	17	30	30	0	0	0	0	0	0	0	15.21	0	0	11.8	0.1	1.2
2025	10	10	17	40	30	0	0	0	0	0	0	0	15.2	0	0	11.6	0.1	1.2
2025	10	10	17	50	30	0	0	0	0	0	0	0	15.19	0	0	11.6	0.1	1.2
2025	10	10	18	0	30	0	0	0	0	0	0	0	15.17	0	0	11.6	0.1	1.2
2025	10	10	18	10	30	0	0	0	0	0	0	0	15.17	0	0	11.6	0.1	1.2
2025	10	10	18	20	30	0	0	0	0	0	0	0	15.16	0	0	11.6	0.1	1.2
2025	10	10	18	30	30	0	0	0	0	0	0	0	15.15	0	0	11.6	0.1	1.2
2025	10	10	18	40	30	0	0	0	0	0	0	0	15.14	0	0	11.6	0.1	1.2
2025	10	10	18	50	30	0	0	0	0	0	0	0	15.13	0	0	11.6	0.1	1.2
2025	10	10	19	0	30	0	0	0	0	0	0	0	15.12	0	0	11.6	0.1	1.2
2025	10	10	19	10	30	0	0	0	0	0	0	0	15.11	0	0	11.6	0.1	1.2
2025	10	10	19	20	30	0	0	0	0	0	0	0	15.1	0	0	11.6	0.1	1.2
2025	10	10	19	30	30	0	0	0	0	0	0	0	15.09	0	0	11.6	0.1	1.2
2025	10	10	19	40	30	0	0	0	0	0	0	0	15.08	0	0	11.6	0.1	1.2
2025	10	10	19	50	30	0	0	0	0	0	0	0	15.07	0	0	11.6	0.1	1.2
2025	10	10	20	0	30	0	0	0	0	0	0	0	15.07	0	0	11.6	0.1	1.2
2025	10	10	20	10	30	0	0	0	0	0	0	0	15.06	0	0	11.6	0.1	1.2
2025	10	10	20	20	30	0	0	0	0	0	0	0	15.05	0	0	11.6	0.1	1.2
2025	10	10	20	30	30	0	0	0	0	0	0	0	15.04	0	0	11.6	0.1	1.2
2025	10	10	20	40	30	0	0	0	0	0	0	0	15.04	0	0	11.6	0.1	1.2
2025	10	10	20	50	30	0	0	0	0	0	0	0	15.03	0	0	11.6	0.1	1.2
2025	10	10	21	0	30	0	0	0	0	0	0	0	15.03	0	0	11.6	0.1	1.2
2025	10	10	21	10	30	0	0	0	0	0	0	0	15.03	0	0	11.6	0.1	1.2
2025	10	10	21	20	30	0	0	0	0	0	0	0	15.02	0	0	11.6	0.1	1.2
2025	10	10	21	30	30	0	0	0	0	0	0	0	15.02	0	0	11.6	0.1	1.2
2025	10	10	21	40	30	0	0	0	0	0	0	0	15.02	0	0	11.6	0.1	1.2
2025	10	10	21	50	30	0	0	0	0	0	0	0	15.02	0	0	11.6	0.1	1.2
2025	10	10	22	0	30	0	0	0	0	0	0	0	15.02	0	0	11.6	0.1	1.2
2025	10	10	22	10	30	0	0	0	0	0	0	0	15.02	0	0	11.4	0.1	1.2
2025	10	10	22	20	30	0	0	0	0	0	0	0	15.02	0	0	11.4	0.1	1.2
2025	10	10	22	30	30	0	0	0	0	0	0	0	15.02	0	0	11.4	0.1	1.2
2025	10	10	22	40	30	0	0	0	0	0	0	0	15.02	0	0	11.4	0.1	1.2
2025	10	10	22	50	30	0	0	0	0	0	0	0	15.02	0	0	11.4	0.1	1.2
2025	10	10	23	0	30	0	0	0	0	0	0	0	15.02	0	0	11.4	0.1	1.2
2025	10	10	23	10	30	0	0	0	0	0	0	0	15.03	0	0	11.4	0.1	1.2
2025	10	10	23	20	30	0	0	0	0	0	0	0	15.03	0	0	11.4	0.1	1.2
2025	10	10	23	30	30	0	0	0	0	0	0	0	15.03	0	0	11.4	0.1	1.2
2025	10	10	23	40	30	0	0	0	0	0	0	0	15.04	0	0	11.6	0.1	1.2
2025	10	10	23	50	30	0	0	0	0	0	0	0	15.04	0	0	11.4	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	11	0	0	30	0	0	0	0	0	0	0	15.04	0	0	11.4	0.1	1.2
2025	10	11	0	10	30	0	0	0	0	0	0	0	15.05	0	0	11.4	0.1	1.2
2025	10	11	0	20	30	0	0	0	0	0	0	0	15.05	0	0	11.4	0.1	1.2
2025	10	11	0	30	30	0	0	0	0	0	0	0	15.05	0	0	11.4	0.1	1.2
2025	10	11	0	40	30	0	0	0	0	0	0	0	15.05	0	0	11.4	0.1	1.2
2025	10	11	0	50	30	0	0	0	0	0	0	0	15.07	0	0	11.4	0.1	1.2
2025	10	11	1	0	30	0	0	0	0	0	0	0	15.07	0	0	11.4	0.1	1.2
2025	10	11	1	10	30	0	0	0	0	0	0	0	15.08	0	0	11.4	0.1	1.2
2025	10	11	1	20	30	0	0	0	0	0	0	0	15.08	0	0	11.4	0.1	1.2
2025	10	11	1	30	30	0	0	0	0	0	0	0	15.09	0	0	11.4	0.1	1.2
2025	10	11	1	40	30	0	0	0	0	0	0	0	15.1	0	0	11.4	0.1	1.2
2025	10	11	1	50	30	0	0	0	0	0	0	0	15.11	0	0	11.4	0.1	1.2
2025	10	11	2	0	30	0	0	0	0	0	0	0	15.12	0	0	11.4	0.1	1.2
2025	10	11	2	10	30	0	0	0	0	0	0	0	15.12	0	0	11.4	0.1	1.2
2025	10	11	2	20	30	0	0	0	0	0	0	0	15.14	0	0	11.4	0.1	1.2
2025	10	11	2	30	30	0	0	0	0	0	0	0	15.14	0	0	11.4	0.1	1.2
2025	10	11	2	40	30	0	0	0	0	0	0	0	15.15	0	0	11.4	0.1	1.2
2025	10	11	2	50	30	0	0	0	0	0	0	0	15.16	0	0	11.4	0.1	1.2
2025	10	11	3	0	30	0	0	0	0	0	0	0	15.16	0	0	11.4	0.1	1.2
2025	10	11	3	10	30	0	0	0	0	0	0	0	15.17	0	0	11.4	0.1	1.2
2025	10	11	3	20	30	0	0	0	0	0	0	0	15.17	0	0	11.4	0.1	1.2
2025	10	11	3	30	30	0	0	0	0	0	0	0	15.17	0	0	11.4	0.1	1.2
2025	10	11	3	40	30	0	0	0	0	0	0	0	15.17	0	0	11.4	0.1	1.2
2025	10	11	3	50	30	0	0	0	0	0	0	0	15.17	0	0	11.4	0.1	1.2
2025	10	11	4	0	30	0	0	0	0	0	0	0	15.18	0	0	11.2	0.1	1.2
2025	10	11	4	10	30	0	0	0	0	0	0	0	15.18	0	0	11.2	0.1	1.2
2025	10	11	4	20	30	0	0	0	0	0	0	0	15.18	0	0	11.4	0.1	1.2
2025	10	11	4	30	30	0	0	0	0	0	0	0	15.18	0	0	11.4	0.1	1.2
2025	10	11	4	40	30	0	0	0	0	0	0	0	15.18	0	0	11.4	0.1	1.2
2025	10	11	4	50	30	0	0	0	0	0	0	0	15.19	0	0	11.4	0.1	1.2
2025	10	11	5	0	30	0	0	0	0	0	0	0	15.19	0	0	11.4	0.1	1.2
2025	10	11	5	10	30	0	0	0	0	0	0	0	15.19	0	0	11.4	0.1	1.2
2025	10	11	5	20	30	0	0	0	0	0	0	0	15.19	0	0	11.4	0.1	1.2
2025	10	11	5	30	30	0	0	0	0	0	0	0	15.18	0	0	11.4	0.1	1.2
2025	10	11	5	40	30	0	0	0	0	0	0	0	15.17	0	0	11.4	0.1	1.2
2025	10	11	5	50	30	0	0	0	0	0	0	0	15.17	0	0	11.4	0.1	1.2
2025	10	11	6	0	30	0	0	0	0	0	0	0	15.16	0	0	11.4	0.1	1.2
2025	10	11	6	10	30	0	0	0	0	0	0	0	15.15	0	0	11.4	0.1	1.2
2025	10	11	6	20	30	0	0	0	0	0	0	0	15.13	0	0	11.4	0.1	1.2
2025	10	11	6	30	30	0	0	0	0	0	0	0	15.12	0	0	11.4	0.1	1.2
2025	10	11	6	40	30	0	0	0	0	0	0	0	15.11	0	0	11.4	0.1	1.2
2025	10	11	6	50	30	0	0	0	0	0	0	0	15.1	0	0	11.4	0.1	1.2
2025	10	11	7	0	30	0	0	0	0	0	0	0	15.09	0	0	11.4	0.1	1.2
2025	10	11	7	10	30	0	0	0	0	0	0	0	15.07	0	0	11.4	0.1	1.2
2025	10	11	7	20	30	0	0	0	0	0	0	0	15.07	0	0	11.4	0.1	1.2
2025	10	11	7	30	30	0	0	0	0	0	0	0	15.06	0	0	11.4	0.1	1.2
2025	10	11	7	40	30	0	0	0	0	0	0	0	15.05	0	0	11.4	0.1	1.2
2025	10	11	7	50	30	0	0	0	0	0	0	0	15.03	0	0	11.6	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	11	8	0	30	0	0	0	0	0	0	0	15.02	0	0	12	0.1	1.2
2025	10	11	8	10	30	0	0	0	0	0	0	0	15.02	0	0	12	0.1	1.2
2025	10	11	8	20	30	0	0	0	0	0	0	0	15.01	0	0	12.2	0.1	1.2
2025	10	11	8	30	30	0	0	0	0	0	0	0	15.01	0	0	12.2	0.1	1.2
2025	10	11	8	40	30	0	0	0	0	0	0	0	15.01	0	0	12.4	0.1	1.2
2025	10	11	8	50	30	0	0	0	0	0	0	0	15.03	0	0	12.4	0.1	1.2
2025	10	11	9	0	30	0	0	0	0	0	0	0	15.04	0	0	12.4	0.1	1.2
2025	10	11	9	10	30	0	0	0	0	0	0	0	15.06	0	0	12.4	0.1	1.2
2025	10	11	9	20	30	0	0	0	0	0	0	0	15.07	0	0	12.6	0.1	1.2
2025	10	11	9	30	30	0	0	0	0	0	0	0	15.08	0	0	12.6	0.1	1.2
2025	10	11	9	40	30	0	0	0	0	0	0	0	15.09	0	0	12.8	0.1	1.2
2025	10	11	9	50	30	0	0	0	0	0	0	0	15.1	0	0	13	0.1	1.2
2025	10	11	10	0	30	0	0	0	0	0	0	0	15.11	0	0	13.2	0.1	1.2
2025	10	11	10	10	30	0	0	0	0	0	0	0	15.13	0	0	13.4	0.1	1.2
2025	10	11	10	20	30	0	0	0	0	0	0	0	15.14	0	0	14.2	0.1	1.2
2025	10	11	10	30	30	0	0	0	0	0	0	0	15.16	0	0	13.6	0.1	1.2
2025	10	11	10	40	30	0	0	0	0	0	0	0	15.16	0	0	14.2	0.1	1.2
2025	10	11	10	50	30	0	0	0	0	0	0	0	15.2	0	0	14.2	0.1	1.2
2025	10	11	11	0	30	0	0	0	0	0	0	0	15.21	0	0	14.2	0.1	1.2
2025	10	11	11	10	30	0	0	0	0	0	0	0	15.22	0	0	14.2	0.1	1.2
2025	10	11	11	20	30	0	0	0	0	0	0	0	15.24	0	0	14.2	0.1	1.2
2025	10	11	11	30	30	0	0	0	0	0	0	0	15.25	0	0	13.4	0.1	1.2
2025	10	11	11	40	30	0	0	0	0	0	0	0	15.26	0	0	13.6	0.1	1.2
2025	10	11	11	50	30	0	0	0	0	0	0	0	15.28	0	0	13.6	0.1	1.2
2025	10	11	12	0	30	0	0	0	0	0	0	0	15.29	0	0	13.6	0.1	1.2
2025	10	11	12	10	30	0	0	0	0	0	0	0	15.3	0	0	13.6	0.1	1.2
2025	10	11	12	20	30	0	0	0	0	0	0	0	15.31	0	0	13.6	0.1	1.2
2025	10	11	12	30	30	0	0	0	0	0	0	0	15.32	0	0	13.6	0.1	1.2
2025	10	11	12	40	30	0	0	0	0	0	0	0	15.34	0	0	13.6	0.1	1.2
2025	10	11	12	50	30	0	0	0	0	0	0	0	15.35	0	0	13.6	0.1	1.2
2025	10	11	13	0	30	0	0	0	0	0	0	0	15.36	0	0	13.6	0.1	1.2
2025	10	11	13	10	30	0	0	0	0	0	0	0	15.36	0	0	13.6	0.1	1.2
2025	10	11	13	20	30	0	0	0	0	0	0	0	15.39	0	0	13.6	0.1	1.2
2025	10	11	13	30	30	0	0	0	0	0	0	0	15.39	0	0	13.6	0.1	1.2
2025	10	11	13	40	30	0	0	0	0	0	0	0	15.38	0	0	13.6	0.1	1.2
2025	10	11	13	50	30	0	0	0	0	0	0	0	15.37	0	0	13.6	0.1	1.2
2025	10	11	14	0	30	0	0	0	0	0	0	0	15.35	0	0	13.6	0.1	1.2
2025	10	11	14	10	30	0	0	0	0	0	0	0	15.31	0	0	13.6	0.1	1.2
2025	10	11	14	20	30	0	0	0	0	0	0	0	15.28	0	0	13.6	0.1	1.2
2025	10	11	14	30	30	0	0	0	0	0	0	0	15.27	0	0	13.6	0.1	1.2
2025	10	11	14	40	30	0	0	0	0	0	0	0	15.28	0	0	13.6	0.1	1.2
2025	10	11	14	50	30	0	0	0	0	0	0	0	15.29	0	0	13.6	0.1	1.2
2025	10	11	15	0	30	0	0	0	0	0	0	0	15.29	0	0	13.6	0.1	1.2
2025	10	11	15	10	30	0	0	0	0	0	0	0	15.29	0	0	13.6	0.1	1.2
2025	10	11	15	20	30	0	0	0	0	0	0	0	15.28	0	0	13.6	0.1	1.2
2025	10	11	15	30	30	0	0	0	0	0	0	0	15.27	0	0	13.6	0.1	1.2
2025	10	11	15	40	30	0	0	0	0	0	0	0	15.26	0	0	13.6	0.1	1.2
2025	10	11	15	50	30	0	0	0	0	0	0	0	15.25	0	0	13.6	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	11	16	0	30	0	0	0	0	0	0	0	15.23	0	0	13.6	0.1	1.2
2025	10	11	16	10	30	0	0	0	0	0	0	0	15.2	0	0	13.6	0.1	1.2
2025	10	11	16	20	30	0	0	0	0	0	0	0	15.19	0	0	13.6	0.1	1.2
2025	10	11	16	30	30	0	0	0	0	0	0	0	15.16	0	0	13	0.1	1.2
2025	10	11	16	40	30	0	0	0	0	0	0	0	15.13	0	0	12.6	0.1	1.2
2025	10	11	16	50	30	0	0	0	0	0	0	0	15.11	0	0	12.4	0.1	1.2
2025	10	11	17	0	30	0	0	0	0	0	0	0	15.07	0	0	12.2	0.1	1.2
2025	10	11	17	10	30	0	0	0	0	0	0	0	15.06	0	0	12.2	0.1	1.2
2025	10	11	17	20	30	0	0	0	0	0	0	0	15.03	0	0	12	0.1	1.2
2025	10	11	17	30	30	0	0	0	0	0	0	0	15.01	0	0	12	0.1	1.2
2025	10	11	17	40	30	0	0	0	0	0	0	0	14.98	0	0	11.8	0.1	1.2
2025	10	11	17	50	30	0	0	0	0	0	0	0	14.96	0	0	11.8	0.1	1.2
2025	10	11	18	0	30	0	0	0	0	0	0	0	14.94	0	0	11.8	0.1	1.2
2025	10	11	18	10	30	0	0	0	0	0	0	0	14.91	0	0	11.8	0.1	1.2
2025	10	11	18	20	30	0	0	0	0	0	0	0	14.89	0	0	11.8	0.1	1.2
2025	10	11	18	30	30	0	0	0	0	0	0	0	14.87	0	0	11.8	0.1	1.2
2025	10	11	18	40	30	0	0	0	0	0	0	0	14.85	0	0	11.8	0.1	1.2
2025	10	11	18	50	30	0	0	0	0	0	0	0	14.82	0	0	11.8	0.1	1.2
2025	10	11	19	0	30	0	0	0	0	0	0	0	14.79	0	0	11.8	0.1	1.2
2025	10	11	19	10	30	0	0	0	0	0	0	0	14.77	0	0	11.8	0.1	1.2
2025	10	11	19	20	30	0	0	0	0	0	0	0	14.76	0	0	11.8	0.1	1.2
2025	10	11	19	30	30	0	0	0	0	0	0	0	14.74	0	0	11.8	0.1	1.2
2025	10	11	19	40	30	0	0	0	0	0	0	0	14.71	0	0	11.8	0.1	1.2
2025	10	11	19	50	30	0	0	0	0	0	0	0	14.69	0	0	11.8	0.1	1.2
2025	10	11	20	0	30	0	0	0	0	0	0	0	14.67	0	0	11.8	0.1	1.2
2025	10	11	20	10	30	0	0	0	0	0	0	0	14.65	0	0	11.8	0.1	1.2
2025	10	11	20	20	30	0	0	0	0	0	0	0	14.62	0	0	11.8	0.1	1.2
2025	10	11	20	30	30	0	0	0	0	0	0	0	14.6	0	0	11.8	0.1	1.2
2025	10	11	20	40	30	0	0	0	0	0	0	0	14.57	0	0	11.8	0.1	1.2
2025	10	11	20	50	30	0	0	0	0	0	0	0	14.55	0	0	11.6	0.1	1.2
2025	10	11	21	0	30	0	0	0	0	0	0	0	14.54	0	0	11.6	0.1	1.2
2025	10	11	21	10	30	0	0	0	0	0	0	0	14.52	0	0	11.6	0.1	1.2
2025	10	11	21	20	30	0	0	0	0	0	0	0	14.51	0	0	11.6	0.1	1.2
2025	10	11	21	30	30	0	0	0	0	0	0	0	14.5	0	0	11.6	0.1	1.2
2025	10	11	21	40	30	0	0	0	0	0	0	0	14.48	0	0	11.6	0.1	1.2
2025	10	11	21	50	30	0	0	0	0	0	0	0	14.48	0	0	11.6	0.1	1.2
2025	10	11	22	0	30	0	0	0	0	0	0	0	14.47	0	0	11.6	0.1	1.2
2025	10	11	22	10	30	0	0	0	0	0	0	0	14.47	0	0	11.6	0.1	1.2
2025	10	11	22	20	30	0	0	0	0	0	0	0	14.46	0	0	11.6	0.1	1.2
2025	10	11	22	30	30	0	0	0	0	0	0	0	14.45	0	0	11.6	0.1	1.2
2025	10	11	22	40	30	0	0	0	0	0	0	0	14.44	0	0	11.6	0.1	1.2
2025	10	11	22	50	30	0	0	0	0	0	0	0	14.43	0	0	11.6	0.1	1.2
2025	10	11	23	0	30	0	0	0	0	0	0	0	14.42	0	0	11.6	0.1	1.2
2025	10	11	23	10	30	0	0	0	0	0	0	0	14.41	0	0	11.6	0.1	1.2
2025	10	11	23	20	30	0	0	0	0	0	0	0	14.41	0	0	11.6	0.1	1.2
2025	10	11	23	30	30	0	0	0	0	0	0	0	14.4	0	0	11.6	0.1	1.2
2025	10	11	23	40	30	0	0	0	0	0	0	0	14.4	0	0	11.6	0.1	1.2
2025	10	11	23	50	30	0	0	0	0	0	0	0	14.39	0	0	11.6	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	12	0	0	30	0	0	0	0	0	0	0	14.39	0	0	11.6	0.1	1.2
2025	10	12	0	10	30	0	0	0	0	0	0	0	14.38	0	0	11.6	0.1	1.2
2025	10	12	0	20	30	0	0	0	0	0	0	0	14.37	0	0	11.6	0.1	1.2
2025	10	12	0	30	30	0	0	0	0	0	0	0	14.36	0	0	11.6	0.1	1.1
2025	10	12	0	40	30	0	0	0	0	0	0	0	14.36	0	0	11.6	0.1	1.1
2025	10	12	0	50	30	0	0	0	0	0	0	0	14.35	0	0	11.6	0.1	1.1
2025	10	12	1	0	30	0	0	0	0	0	0	0	14.35	0	0	11.6	0.1	1.1
2025	10	12	1	10	30	0	0	0	0	0	0	0	14.34	0	0	11.6	0.1	1.1
2025	10	12	1	20	30	0	0	0	0	0	0	0	14.34	0	0	11.6	0.1	1.1
2025	10	12	1	30	30	0	0	0	0	0	0	0	14.34	0	0	11.6	0.1	1.1
2025	10	12	1	40	30	0	0	0	0	0	0	0	14.33	0	0	11.6	0.1	1.1
2025	10	12	1	50	30	0	0	0	0	0	0	0	14.33	0	0	11.6	0.1	1.1
2025	10	12	2	0	30	0	0	0	0	0	0	0	14.32	0	0	11.6	0.1	1.1
2025	10	12	2	10	30	0	0	0	0	0	0	0	14.31	0	0	11.6	0.1	1.1
2025	10	12	2	20	30	0	0	0	0	0	0	0	14.3	0	0	11.6	0.1	1.1
2025	10	12	2	30	30	0	0	0	0	0	0	0	14.3	0	0	11.6	0.1	1.1
2025	10	12	2	40	30	0	0	0	0	0	0	0	14.29	0	0	11.6	0.1	1.1
2025	10	12	2	50	30	0	0	0	0	0	0	0	14.28	0	0	11.6	0.1	1.1
2025	10	12	3	0	30	0	0	0	0	0	0	0	14.28	0	0	11.6	0.1	1.1
2025	10	12	3	10	30	0	0	0	0	0	0	0	14.26	0	0	11.6	0.1	1.1
2025	10	12	3	20	30	0	0	0	0	0	0	0	14.25	0	0	11.6	0.1	1.1
2025	10	12	3	30	30	0	0	0	0	0	0	0	14.24	0	0	11.6	0.1	1.1
2025	10	12	3	40	30	0	0	0	0	0	0	0	14.24	0	0	11.6	0.1	1.1
2025	10	12	3	50	30	0	0	0	0	0	0	0	14.22	0	0	11.6	0.1	1.1
2025	10	12	4	0	30	0	0	0	0	0	0	0	14.21	0	0	11.6	0.1	1.1
2025	10	12	4	10	30	0	0	0	0	0	0	0	14.21	0	0	11.6	0.1	1.1
2025	10	12	4	20	30	0	0	0	0	0	0	0	14.19	0	0	11.6	0.1	1.1
2025	10	12	4	30	30	0	0	0	0	0	0	0	14.18	0	0	11.6	0.1	1.1
2025	10	12	4	40	30	0	0	0	0	0	0	0	14.17	0	0	11.6	0.1	1.1
2025	10	12	4	50	30	0	0	0	0	0	0	0	14.15	0	0	11.6	0.1	1.1
2025	10	12	5	0	30	0	0	0	0	0	0	0	14.14	0	0	11.6	0.1	1.1
2025	10	12	5	10	30	0	0	0	0	0	0	0	14.13	0	0	11.6	0.1	1.1
2025	10	12	5	20	30	0	0	0	0	0	0	0	14.12	0	0	11.6	0.1	1.1
2025	10	12	5	30	30	0	0	0	0	0	0	0	14.1	0	0	11.6	0.1	1.1
2025	10	12	5	40	30	0	0	0	0	0	0	0	14.09	0	0	11.4	0.1	1.1
2025	10	12	5	50	30	0	0	0	0	0	0	0	14.08	0	0	11.4	0.1	1.1
2025	10	12	6	0	30	0	0	0	0	0	0	0	14.07	0	0	11.4	0.1	1.1
2025	10	12	6	10	30	0	0	0	0	0	0	0	14.06	0	0	11.4	0.1	1.1
2025	10	12	6	20	30	0	0	0	0	0	0	0	14.05	0	0	11.4	0.1	1.1
2025	10	12	6	30	30	0	0	0	0	0	0	0	14.04	0	0	11.4	0.1	1.1
2025	10	12	6	40	30	0	0	0	0	0	0	0	14.03	0	0	11.4	0.1	1.1
2025	10	12	6	50	30	0	0	0	0	0	0	0	14.01	0	0	11.4	0.1	1.1
2025	10	12	7	0	30	0	0	0	0	0	0	0	14	0	0	11.4	0.1	1.1
2025	10	12	7	10	30	0	0	0	0	0	0	0	13.99	0	0	11.4	0.1	1.1
2025	10	12	7	20	30	0	0	0	0	0	0	0	13.98	0	0	11.4	0.1	1.1
2025	10	12	7	30	30	0	0	0	0	0	0	0	13.97	0	0	11.4	0.1	1.1
2025	10	12	7	40	30	0	0	0	0	0	0	0	13.95	0	0	11.6	0.1	1.1
2025	10	12	7	50	30	0	0	0	0	0	0	0	13.94	0	0	11.8	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	12	8	0	30	0	0	0	0	0	0	0	13.93	0	0	12	0.1	1.1
2025	10	12	8	10	30	0	0	0	0	0	0	0	13.92	0	0	12.2	0.1	1.1
2025	10	12	8	20	30	0	0	0	0	0	0	0	13.91	0	0	12.4	0.1	1.1
2025	10	12	8	30	30	0	0	0	0	0	0	0	13.9	0	0	12.4	0.1	1.1
2025	10	12	8	40	30	0	0	0	0	0	0	0	13.9	0	0	12.6	0.1	1.1
2025	10	12	8	50	30	0	0	0	0	0	0	0	13.92	0	0	12.6	0.1	1.1
2025	10	12	9	0	30	0	0	0	0	0	0	0	13.95	0	0	12.6	0.1	1.1
2025	10	12	9	10	30	0	0	0	0	0	0	0	13.95	0	0	12.8	0.1	1.1
2025	10	12	9	20	30	0	0	0	0	0	0	0	13.96	0	0	12.8	0.1	1.1
2025	10	12	9	30	30	0	0	0	0	0	0	0	13.96	0	0	13	0.1	1.1
2025	10	12	9	40	30	0	0	0	0	0	0	0	13.98	0	0	13.4	0.1	1.1
2025	10	12	9	50	30	0	0	0	0	0	0	0	13.98	0	0	13.6	0.1	1.1
2025	10	12	10	0	30	0	0	0	0	0	0	0	13.99	0	0	14	0.1	1.1
2025	10	12	10	10	30	0	0	0	0	0	0	0	14.01	0	0	14	0.1	1.1
2025	10	12	10	20	30	0	0	0	0	0	0	0	14.01	0	0	13.8	0.1	1.1
2025	10	12	10	30	30	0	0	0	0	0	0	0	14.03	0	0	13.8	0.1	1.1
2025	10	12	10	40	30	0	0	0	0	0	0	0	14.03	0	0	13.8	0.1	1.1
2025	10	12	10	50	30	0	0	0	0	0	0	0	14.05	0	0	13.8	0.1	1.1
2025	10	12	11	0	30	0	0	0	0	0	0	0	14.06	0	0	13.8	0.1	1.1
2025	10	12	11	10	30	0	0	0	0	0	0	0	14.06	0	0	13.8	0.1	1.1
2025	10	12	11	20	30	0	0	0	0	0	0	0	14.08	0	0	13.8	0.1	1.1
2025	10	12	11	30	30	0	0	0	0	0	0	0	14.12	0	0	13.8	0.1	1.1
2025	10	12	11	40	30	0	0	0	0	0	0	0	14.15	0	0	13.8	0.1	1.1
2025	10	12	11	50	30	0	0	0	0	0	0	0	14.15	0	0	13.8	0.1	1.1
2025	10	12	12	0	30	0	0	0	0	0	0	0	14.17	0	0	13.8	0.1	1.1
2025	10	12	12	10	30	0	0	0	0	0	0	0	14.18	0	0	13.8	0.1	1.1
2025	10	12	12	20	30	0	0	0	0	0	0	0	14.19	0	0	13.6	0.1	1.1
2025	10	12	12	30	30	0	0	0	0	0	0	0	14.19	0	0	13.6	0.1	1.1
2025	10	12	12	40	30	0	0	0	0	0	0	0	14.19	0	0	13.6	0.1	1.1
2025	10	12	12	50	30	0	0	0	0	0	0	0	14.2	0	0	13.6	0.1	1.1
2025	10	12	13	0	30	0	0	0	0	0	0	0	14.19	0	0	13.6	0.1	1.1
2025	10	12	13	10	30	0	0	0	0	0	0	0	14.2	0	0	13.6	0.1	1.1
2025	10	12	13	20	30	0	0	0	0	0	0	0	14.2	0	0	13.6	0.1	1.1
2025	10	12	13	30	30	0	0	0	0	0	0	0	14.21	0	0	13.6	0.1	1.1
2025	10	12	13	40	30	0	0	0	0	0	0	0	14.2	0	0	13.6	0.1	1.1
2025	10	12	13	50	30	0	0	0	0	0	0	0	14.2	0	0	13.6	0.1	1.1
2025	10	12	14	0	30	0	0	0	0	0	0	0	14.2	0	0	13.6	0.1	1.1
2025	10	12	14	10	30	0	0	0	0	0	0	0	14.2	0	0	13.6	0.1	1.1
2025	10	12	14	20	30	0	0	0	0	0	0	0	14.18	0	0	13.6	0.1	1.1
2025	10	12	14	30	30	0	0	0	0	0	0	0	14.18	0	0	13.6	0.1	1.1
2025	10	12	14	40	30	0	0	0	0	0	0	0	14.17	0	0	13.6	0.1	1.1
2025	10	12	14	50	30	0	0	0	0	0	0	0	14.17	0	0	13.4	0.1	1.1
2025	10	12	15	0	30	0	0	0	0	0	0	0	14.16	0	0	13.4	0.1	1.1
2025	10	12	15	10	30	0	0	0	0	0	0	0	14.14	0	0	13.6	0.1	1.1
2025	10	12	15	20	30	0	0	0	0	0	0	0	14.14	0	0	13.6	0.1	1.1
2025	10	12	15	30	30	0	0	0	0	0	0	0	14.13	0	0	13.6	0.1	1.1
2025	10	12	15	40	30	0	0	0	0	0	0	0	14.11	0	0	13.4	0.1	1.1
2025	10	12	15	50	30	0	0	0	0	0	0	0	14.1	0	0	13.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	12	16	0	30	0	0	0	0	0	0	0	14.09	0	0	13.6	0.1	1.1
2025	10	12	16	10	30	0	0	0	0	0	0	0	14.07	0	0	13.6	0.1	1.1
2025	10	12	16	20	30	0	0	0	0	0	0	0	14.05	0	0	13.6	0.1	1.1
2025	10	12	16	30	30	0	0	0	0	0	0	0	14.03	0	0	13.2	0.1	1.1
2025	10	12	16	40	30	0	0	0	0	0	0	0	14.01	0	0	12.6	0.1	1.1
2025	10	12	16	50	30	0	0	0	0	0	0	0	14	0	0	12.4	0.1	1.1
2025	10	12	17	0	30	0	0	0	0	0	0	0	13.98	0	0	12.2	0.1	1.1
2025	10	12	17	10	30	0	0	0	0	0	0	0	13.96	0	0	12	0.1	1.1
2025	10	12	17	20	30	0	0	0	0	0	0	0	13.95	0	0	11.8	0.1	1.1
2025	10	12	17	30	30	0	0	0	0	0	0	0	13.94	0	0	11.8	0.1	1.1
2025	10	12	17	40	30	0	0	0	0	0	0	0	13.92	0	0	11.6	0.1	1.1
2025	10	12	17	50	30	0	0	0	0	0	0	0	13.91	0	0	11.6	0.1	1.1
2025	10	12	18	0	30	0	0	0	0	0	0	0	13.89	0	0	11.6	0.1	1.1
2025	10	12	18	10	30	0	0	0	0	0	0	0	13.88	0	0	11.6	0.1	1.1
2025	10	12	18	20	30	0	0	0	0	0	0	0	13.87	0	0	11.6	0.1	1.1
2025	10	12	18	30	30	0	0	0	0	0	0	0	13.84	0	0	11.6	0.1	1.1
2025	10	12	18	40	30	0	0	0	0	0	0	0	13.82	0	0	11.6	0.1	1.1
2025	10	12	18	50	30	0	0	0	0	0	0	0	13.79	0	0	11.6	0.1	1.1
2025	10	12	19	0	30	0	0	0	0	0	0	0	13.77	0	0	11.6	0.1	1.1
2025	10	12	19	10	30	0	0	0	0	0	0	0	13.74	0	0	11.6	0.1	1.1
2025	10	12	19	20	30	0	0	0	0	0	0	0	13.72	0	0	11.6	0.1	1.1
2025	10	12	19	30	30	0	0	0	0	0	0	0	13.7	0	0	11.6	0.1	1.1
2025	10	12	19	40	30	0	0	0	0	0	0	0	13.68	0	0	11.6	0.1	1.1
2025	10	12	19	50	30	0	0	0	0	0	0	0	13.65	0	0	11.6	0.1	1.1
2025	10	12	20	0	30	0	0	0	0	0	0	0	13.62	0	0	11.6	0.1	1.1
2025	10	12	20	10	30	0	0	0	0	0	0	0	13.59	0	0	11.6	0.1	1.1
2025	10	12	20	20	30	0	0	0	0	0	0	0	13.57	0	0	11.6	0.1	1.1
2025	10	12	20	30	30	0	0	0	0	0	0	0	13.55	0	0	11.6	0.1	1.1
2025	10	12	20	40	30	0	0	0	0	0	0	0	13.53	0	0	11.6	0.1	1.1
2025	10	12	20	50	30	0	0	0	0	0	0	0	13.51	0	0	11.6	0.1	1.1
2025	10	12	21	0	30	0	0	0	0	0	0	0	13.48	0	0	11.6	0.1	1.1
2025	10	12	21	10	30	0	0	0	0	0	0	0	13.46	0	0	11.6	0.1	1.1
2025	10	12	21	20	30	0	0	0	0	0	0	0	13.44	0	0	11.6	0.1	1.1
2025	10	12	21	30	30	0	0	0	0	0	0	0	13.42	0	0	11.6	0.1	1.1
2025	10	12	21	40	30	0	0	0	0	0	0	0	13.39	0	0	11.6	0.1	1.1
2025	10	12	21	50	30	0	0	0	0	0	0	0	13.37	0	0	11.6	0.1	1.1
2025	10	12	22	0	30	0	0	0	0	0	0	0	13.36	0	0	11.6	0.1	1.1
2025	10	12	22	10	30	0	0	0	0	0	0	0	13.33	0	0	11.6	0.1	1.1
2025	10	12	22	20	30	0	0	0	0	0	0	0	13.31	0	0	11.6	0.1	1.1
2025	10	12	22	30	30	0	0	0	0	0	0	0	13.3	0	0	11.6	0.1	1.1
2025	10	12	22	40	30	0	0	0	0	0	0	0	13.27	0	0	11.6	0.1	1.1
2025	10	12	22	50	30	0	0	0	0	0	0	0	13.25	0	0	11.6	0.1	1.1
2025	10	12	23	0	30	0	0	0	0	0	0	0	13.24	0	0	11.6	0.1	1.1
2025	10	12	23	10	30	0	0	0	0	0	0	0	13.22	0	0	11.6	0.1	1.1
2025	10	12	23	20	30	0	0	0	0	0	0	0	13.21	0	0	11.6	0.1	1.1
2025	10	12	23	30	30	0	0	0	0	0	0	0	13.18	0	0	11.6	0.1	1.1
2025	10	12	23	40	30	0	0	0	0	0	0	0	13.18	0	0	11.6	0.1	1.1
2025	10	12	23	50	30	0	0	0	0	0	0	0	13.16	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	13	0	0	30	0	0	0	0	0	0	0	13.14	0	0	11.6	0.1	1.1
2025	10	13	0	10	30	0	0	0	0	0	0	0	13.13	0	0	11.4	0.1	1.1
2025	10	13	0	20	30	0	0	0	0	0	0	0	13.12	0	0	11.4	0.1	1.1
2025	10	13	0	30	30	0	0	0	0	0	0	0	13.11	0	0	11.4	0.1	1.1
2025	10	13	0	40	30	0	0	0	0	0	0	0	13.1	0	0	11.4	0.1	1.1
2025	10	13	0	50	30	0	0	0	0	0	0	0	13.08	0	0	11.4	0.1	1.1
2025	10	13	1	0	30	0	0	0	0	0	0	0	13.08	0	0	11.4	0.1	1.1
2025	10	13	1	10	30	0	0	0	0	0	0	0	13.07	0	0	11.4	0.1	1.1
2025	10	13	1	20	30	0	0	0	0	0	0	0	13.06	0	0	11.4	0.1	1.1
2025	10	13	1	30	30	0	0	0	0	0	0	0	13.06	0	0	11.4	0.1	1.1
2025	10	13	1	40	30	0	0	0	0	0	0	0	13.05	0	0	11.4	0.1	1.1
2025	10	13	1	50	30	0	0	0	0	0	0	0	13.04	0	0	11.4	0.1	1.1
2025	10	13	2	0	30	0	0	0	0	0	0	0	13.04	0	0	11.4	0.1	1.1
2025	10	13	2	10	30	0	0	0	0	0	0	0	13.02	0	0	11.4	0.1	1.1
2025	10	13	2	20	30	0	0	0	0	0	0	0	13.02	0	0	11.4	0.1	1.1
2025	10	13	2	30	30	0	0	0	0	0	0	0	13.01	0	0	11.4	0.1	1.1
2025	10	13	2	40	30	0	0	0	0	0	0	0	13	0	0	11.4	0.1	1.1
2025	10	13	2	50	30	0	0	0	0	0	0	0	13	0	0	11.4	0.1	1.1
2025	10	13	3	0	30	0	0	0	0	0	0	0	12.99	0	0	11.4	0.1	1.1
2025	10	13	3	10	30	0	0	0	0	0	0	0	12.98	0	0	11.4	0.1	1.1
2025	10	13	3	20	30	0	0	0	0	0	0	0	12.98	0	0	11.4	0.1	1.1
2025	10	13	3	30	30	0	0	0	0	0	0	0	12.97	0	0	11.4	0.1	1.1
2025	10	13	3	40	30	0	0	0	0	0	0	0	12.96	0	0	11.4	0.1	1.1
2025	10	13	3	50	30	0	0	0	0	0	0	0	12.95	0	0	11.4	0.1	1.1
2025	10	13	4	0	30	0	0	0	0	0	0	0	12.95	0	0	11.4	0.1	1.1
2025	10	13	4	10	30	0	0	0	0	0	0	0	12.94	0	0	11.4	0.1	1.1
2025	10	13	4	20	30	0	0	0	0	0	0	0	12.93	0	0	11.2	0.1	1.1
2025	10	13	4	30	30	0	0	0	0	0	0	0	12.92	0	0	11.2	0.1	1.1
2025	10	13	4	40	30	0	0	0	0	0	0	0	12.91	0	0	11.2	0.1	1.1
2025	10	13	4	50	30	0	0	0	0	0	0	0	12.91	0	0	11.4	0.1	1.1
2025	10	13	5	0	30	0	0	0	0	0	0	0	12.9	0	0	11.4	0.1	1.1
2025	10	13	5	10	30	0	0	0	0	0	0	0	12.89	0	0	11.2	0.1	1.1
2025	10	13	5	20	30	0	0	0	0	0	0	0	12.88	0	0	11.4	0.1	1.1
2025	10	13	5	30	30	0	0	0	0	0	0	0	12.86	0	0	11.4	0.1	1.1
2025	10	13	5	40	30	0	0	0	0	0	0	0	12.86	0	0	11.4	0.1	1.1
2025	10	13	5	50	30	0	0	0	0	0	0	0	12.84	0	0	11.4	0.1	1.1
2025	10	13	6	0	30	0	0	0	0	0	0	0	12.84	0	0	11.4	0.1	1.1
2025	10	13	6	10	30	0	0	0	0	0	0	0	12.82	0	0	11.4	0.1	1.1
2025	10	13	6	20	30	0	0	0	0	0	0	0	12.81	0	0	11.4	0.1	1.1
2025	10	13	6	30	30	0	0	0	0	0	0	0	12.8	0	0	11.4	0.1	1.1
2025	10	13	6	40	30	0	0	0	0	0	0	0	12.79	0	0	11.4	0.1	1.1
2025	10	13	6	50	30	0	0	0	0	0	0	0	12.78	0	0	11.4	0.1	1.1
2025	10	13	7	0	30	0	0	0	0	0	0	0	12.77	0	0	11.4	0.1	1.1
2025	10	13	7	10	30	0	0	0	0	0	0	0	12.75	0	0	11.4	0.1	1.1
2025	10	13	7	20	30	0	0	0	0	0	0	0	12.74	0	0	11.4	0.1	1.1
2025	10	13	7	30	30	0	0	0	0	0	0	0	12.72	0	0	11.4	0.1	1.1
2025	10	13	7	40	30	0	0	0	0	0	0	0	12.71	0	0	11.6	0.1	1.1
2025	10	13	7	50	30	0	0	0	0	0	0	0	12.7	0	0	11.8	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	13	8	0	30	0	0	0	0	0	0	0	12.69	0	0	12.2	0.1	1.1
2025	10	13	8	10	30	0	0	0	0	0	0	0	12.67	0	0	12.4	0.1	1.1
2025	10	13	8	20	30	0	0	0	0	0	0	0	12.66	0	0	12.6	0.1	1.1
2025	10	13	8	30	30	0	0	0	0	0	0	0	12.65	0	0	12.6	0.1	1.1
2025	10	13	8	40	30	0	0	0	0	0	0	0	12.65	0	0	12.6	0.1	1.1
2025	10	13	8	50	30	0	0	0	0	0	0	0	12.68	0	0	12.8	0.1	1.1
2025	10	13	9	0	30	0	0	0	0	0	0	0	12.7	0	0	12.8	0.1	1.1
2025	10	13	9	10	30	0	0	0	0	0	0	0	12.71	0	0	12.8	0.1	1.1
2025	10	13	9	20	30	0	0	0	0	0	0	0	12.72	0	0	13	0.1	1.1
2025	10	13	9	30	30	0	0	0	0	0	0	0	12.73	0	0	13	0.1	1.1
2025	10	13	9	40	30	0	0	0	0	0	0	0	12.74	0	0	13.2	0.1	1.1
2025	10	13	9	50	30	0	0	0	0	0	0	0	12.76	0	0	13.6	0.1	1.1
2025	10	13	10	0	30	0	0	0	0	0	0	0	12.77	0	0	13.6	0.1	1.1
2025	10	13	10	10	30	0	0	0	0	0	0	0	12.79	0	0	13.6	0.1	1.1
2025	10	13	10	20	30	0	0	0	0	0	0	0	12.81	0	0	13.4	0.1	1.1
2025	10	13	10	30	30	0	0	0	0	0	0	0	12.83	0	0	13.4	0.1	1.1
2025	10	13	10	40	30	0	0	0	0	0	0	0	12.84	0	0	13.4	0.1	1.1
2025	10	13	10	50	30	0	0	0	0	0	0	0	12.83	0	0	13.2	0.1	1.1
2025	10	13	11	0	30	0	0	0	0	0	0	0	12.8	0	0	13.2	0.1	1.1
2025	10	13	11	10	30	0	0	0	0	0	0	0	12.82	0	0	13.2	0.1	1.1
2025	10	13	11	20	30	0	0	0	0	0	0	0	12.8	0	0	13.2	0.1	1.1
2025	10	13	11	30	30	0	0	0	0	0	0	0	12.76	0	0	12.6	0.1	1.1
2025	10	13	11	40	30	0	0	0	0	0	0	0	12.74	0	0	12.6	0.1	1.1
2025	10	13	11	50	30	0	0	0	0	0	0	0	12.75	0	0	12.8	0.1	1.1
2025	10	13	12	0	30	0	0	0	0	0	0	0	12.77	0	0	13.2	0.1	1.1
2025	10	13	12	10	30	0	0	0	0	0	0	0	12.76	0	0	12.8	0.1	1.1
2025	10	13	12	20	30	0	0	0	0	0	0	0	12.79	0	0	13	0.1	1.1
2025	10	13	12	30	30	0	0	0	0	0	0	0	12.86	0	0	13.2	0.1	1.1
2025	10	13	12	40	30	0	0	0	0	0	0	0	12.8	0	0	13	0.1	1.1
2025	10	13	12	50	30	0	0	0	0	0	0	0	12.8	0	0	13.2	0.1	1.1
2025	10	13	13	0	30	0	0	0	0	0	0	0	12.79	0	0	13	0.1	1.1
2025	10	13	13	10	30	0	0	0	0	0	0	0	12.78	0	0	12.6	0.1	1.1
2025	10	13	13	20	30	0	0	0	0	0	0	0	12.75	0	0	12.4	0.1	1.1
2025	10	13	13	30	30	0	0	0	0	0	0	0	12.73	0	0	12.4	0.1	1.1
2025	10	13	13	40	30	0	0	0	0	0	0	0	12.71	0	0	12.4	0.1	1.1
2025	10	13	13	50	30	0	0	0	0	0	0	0	12.7	0	0	12.4	0.1	1.1
2025	10	13	14	0	30	0	0	0	0	0	0	0	12.69	0	0	12.4	0.1	1.1
2025	10	13	14	10	30	0	0	0	0	0	0	0	12.68	0	0	12.2	0.1	1.1
2025	10	13	14	20	30	0	0	0	0	0	0	0	12.67	0	0	12.2	0.1	1.1
2025	10	13	14	30	30	0	0	0	0	0	0	0	12.67	0	0	12.2	0.1	1.1
2025	10	13	14	40	30	0	0	0	0	0	0	0	12.66	0	0	12.2	0.1	1.1
2025	10	13	14	50	30	0	0	0	0	0	0	0	12.66	0	0	12.2	0.1	1.1
2025	10	13	15	0	30	0	0	0	0	0	0	0	12.64	0	0	12	0.1	1.1
2025	10	13	15	10	30	0	0	0	0	0	0	0	12.63	0	0	11.8	0.1	1.1
2025	10	13	15	20	30	0	0	0	0	0	0	0	12.61	0	0	11.6	0.1	1.1
2025	10	13	15	30	30	0	0	0	0	0	0	0	12.6	0	0	11.6	0.1	1.1
2025	10	13	15	40	30	0	0	0	0	0	0	0	12.59	0	0	11.6	0.1	1.1
2025	10	13	15	50	30	0	0	0	0	0	0	0	12.59	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	13	16	0	30	0	0	0	0	0	0	0	12.59	0	0	11.8	0.1	1.1
2025	10	13	16	10	30	0	0	0	0	0	0	0	12.59	0	0	11.8	0.1	1.1
2025	10	13	16	20	30	0	0	0	0	0	0	0	12.58	0	0	11.6	0.1	1.1
2025	10	13	16	30	30	0	0	0	0	0	0	0	12.57	0	0	11.6	0.1	1.1
2025	10	13	16	40	30	0	0	0	0	0	0	0	12.55	0	0	11.6	0.1	1.1
2025	10	13	16	50	30	0	0	0	0	0	0	0	12.54	0	0	11.6	0.1	1.1
2025	10	13	17	0	30	0	0	0	0	0	0	0	12.52	0	0	11.6	0.1	1.1
2025	10	13	17	10	30	0	0	0	0	0	0	0	12.5	0	0	11.6	0.1	1.1
2025	10	13	17	20	30	0	0	0	0	0	0	0	12.48	0	0	11.6	0.1	1.1
2025	10	13	17	30	30	0	0	0	0	0	0	0	12.44	0	0	11.4	0.1	1.1
2025	10	13	17	40	30	0	0	0	0	0	0	0	12.41	0	0	11.4	0.1	1.1
2025	10	13	17	50	30	0	0	0	0	0	0	0	12.39	0	0	11.4	0.1	1.1
2025	10	13	18	0	30	0	0	0	0	0	0	0	12.36	0	0	11.4	0.1	1.1
2025	10	13	18	10	30	0	0	0	0	0	0	0	12.33	0	0	11.4	0.1	1.1
2025	10	13	18	20	30	0	0	0	0	0	0	0	12.29	0	0	11.4	0.1	1.1
2025	10	13	18	30	30	0	0	0	0	0	0	0	12.27	0	0	11.4	0.1	1.1
2025	10	13	18	40	30	0	0	0	0	0	0	0	12.24	0	0	11.4	0.1	1.1
2025	10	13	18	50	30	0	0	0	0	0	0	0	12.21	0	0	11.6	0.1	1.1
2025	10	13	19	0	30	0	0	0	0	0	0	0	12.18	0	0	11.6	0.1	1.1
2025	10	13	19	10	30	0	0	0	0	0	0	0	12.15	0	0	11.6	0.1	1.1
2025	10	13	19	20	30	0	0	0	0	0	0	0	12.13	0	0	11.6	0.1	1.1
2025	10	13	19	30	30	0	0	0	0	0	0	0	12.1	0	0	11.6	0.1	1.1
2025	10	13	19	40	30	0	0	0	0	0	0	0	12.07	0	0	11.6	0.1	1.1
2025	10	13	19	50	30	0	0	0	0	0	0	0	12.05	0	0	11.6	0.1	1.1
2025	10	13	20	0	30	0	0	0	0	0	0	0	12.02	0	0	11.6	0.1	1.1
2025	10	13	20	10	30	0	0	0	0	0	0	0	12	0	0	11.6	0.1	1.1
2025	10	13	20	20	30	0	0	0	0	0	0	0	11.98	0	0	11.6	0.1	1.1
2025	10	13	20	30	30	0	0	0	0	0	0	0	11.95	0	0	11.6	0.1	1.1
2025	10	13	20	40	30	0	0	0	0	0	0	0	11.93	0	0	11.4	0.1	1.1
2025	10	13	20	50	30	0	0	0	0	0	0	0	11.91	0	0	11.4	0.1	1.1
2025	10	13	21	0	30	0	0	0	0	0	0	0	11.89	0	0	11.4	0.1	1.1
2025	10	13	21	10	30	0	0	0	0	0	0	0	11.87	0	0	11.4	0.1	1.1
2025	10	13	21	20	30	0	0	0	0	0	0	0	11.85	0	0	11.4	0.1	1.1
2025	10	13	21	30	30	0	0	0	0	0	0	0	11.84	0	0	11.4	0.1	1.1
2025	10	13	21	40	30	0	0	0	0	0	0	0	11.82	0	0	11.4	0.1	1.1
2025	10	13	21	50	30	0	0	0	0	0	0	0	11.81	0	0	11.4	0.1	1.1
2025	10	13	22	0	30	0	0	0	0	0	0	0	11.8	0	0	11.4	0.1	1.1
2025	10	13	22	10	30	0	0	0	0	0	0	0	11.79	0	0	11.4	0.1	1.1
2025	10	13	22	20	30	0	0	0	0	0	0	0	11.77	0	0	11.4	0.1	1.1
2025	10	13	22	30	30	0	0	0	0	0	0	0	11.76	0	0	11.4	0.1	1.1
2025	10	13	22	40	30	0	0	0	0	0	0	0	11.76	0	0	11.4	0.1	1.1
2025	10	13	22	50	30	0	0	0	0	0	0	0	11.75	0	0	11.4	0.1	1.1
2025	10	13	23	0	30	0	0	0	0	0	0	0	11.74	0	0	11.2	0.1	1.1
2025	10	13	23	10	30	0	0	0	0	0	0	0	11.74	0	0	11.2	0.1	1.1
2025	10	13	23	20	30	0	0	0	0	0	0	0	11.73	0	0	11.2	0.1	1.1
2025	10	13	23	30	30	0	0	0	0	0	0	0	11.73	0	0	11.2	0.1	1.1
2025	10	13	23	40	30	0	0	0	0	0	0	0	11.72	0	0	11.4	0.1	1.1
2025	10	13	23	50	30	0	0	0	0	0	0	0	11.72	0	0	11.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	14	0	0	30	0	0	0	0	0	0	0	11.72	0	0	11.4	0.1	1.1
2025	10	14	0	10	30	0	0	0	0	0	0	0	11.71	0	0	11.4	0.1	1.1
2025	10	14	0	20	30	0	0	0	0	0	0	0	11.71	0	0	11.4	0.1	1.1
2025	10	14	0	30	30	0	0	0	0	0	0	0	11.7	0	0	11.4	0.1	1.1
2025	10	14	0	40	30	0	0	0	0	0	0	0	11.7	0	0	11.4	0.1	1.1
2025	10	14	0	50	30	0	0	0	0	0	0	0	11.7	0	0	11.4	0.1	1.1
2025	10	14	1	0	30	0	0	0	0	0	0	0	11.7	0	0	11.4	0.1	1.1
2025	10	14	1	10	30	0	0	0	0	0	0	0	11.7	0	0	11.4	0.1	1.1
2025	10	14	1	20	30	0	0	0	0	0	0	0	11.7	0	0	11.4	0.1	1.1
2025	10	14	1	30	30	0	0	0	0	0	0	0	11.69	0	0	11.2	0.1	1.1
2025	10	14	1	40	30	0	0	0	0	0	0	0	11.69	0	0	11.2	0.1	1.1
2025	10	14	1	50	30	0	0	0	0	0	0	0	11.7	0	0	11.2	0.1	1.1
2025	10	14	2	0	30	0	0	0	0	0	0	0	11.69	0	0	11.2	0.1	1.1
2025	10	14	2	10	30	0	0	0	0	0	0	0	11.7	0	0	11.2	0.1	1.1
2025	10	14	2	20	30	0	0	0	0	0	0	0	11.7	0	0	11.2	0.1	1.1
2025	10	14	2	30	30	0	0	0	0	0	0	0	11.7	0	0	11.2	0.1	1.1
2025	10	14	2	40	30	0	0	0	0	0	0	0	11.71	0	0	11.2	0.1	1.1
2025	10	14	2	50	30	0	0	0	0	0	0	0	11.71	0	0	11.2	0.1	1.1
2025	10	14	3	0	30	0	0	0	0	0	0	0	11.72	0	0	11.2	0.1	1.1
2025	10	14	3	10	30	0	0	0	0	0	0	0	11.73	0	0	11.2	0.1	1.1
2025	10	14	3	20	30	0	0	0	0	0	0	0	11.73	0	0	11.2	0.1	1.1
2025	10	14	3	30	30	0	0	0	0	0	0	0	11.73	0	0	11.2	0.1	1.1
2025	10	14	3	40	30	0	0	0	0	0	0	0	11.74	0	0	11.2	0.1	1.1
2025	10	14	3	50	30	0	0	0	0	0	0	0	11.74	0	0	11.2	0.1	1.1
2025	10	14	4	0	30	0	0	0	0	0	0	0	11.75	0	0	11.2	0.1	1.1
2025	10	14	4	10	30	0	0	0	0	0	0	0	11.75	0	0	11.2	0.1	1.1
2025	10	14	4	20	30	0	0	0	0	0	0	0	11.76	0	0	11.2	0.1	1.1
2025	10	14	4	30	30	0	0	0	0	0	0	0	11.76	0	0	11.2	0.1	1.1
2025	10	14	4	40	30	0	0	0	0	0	0	0	11.77	0	0	11.2	0.1	1.1
2025	10	14	4	50	30	0	0	0	0	0	0	0	11.77	0	0	11.2	0.1	1.1
2025	10	14	5	0	30	0	0	0	0	0	0	0	11.77	0	0	11.2	0.1	1.1
2025	10	14	5	10	30	0	0	0	0	0	0	0	11.78	0	0	11.2	0.1	1.1
2025	10	14	5	20	30	0	0	0	0	0	0	0	11.77	0	0	11.2	0.1	1.1
2025	10	14	5	30	30	0	0	0	0	0	0	0	11.78	0	0	11.2	0.1	1.1
2025	10	14	5	40	30	0	0	0	0	0	0	0	11.78	0	0	11.2	0.1	1.1
2025	10	14	5	50	30	0	0	0	0	0	0	0	11.77	0	0	11.2	0.1	1.1
2025	10	14	6	0	30	0	0	0	0	0	0	0	11.77	0	0	11.2	0.1	1.1
2025	10	14	6	10	30	0	0	0	0	0	0	0	11.77	0	0	11.2	0.1	1.1
2025	10	14	6	20	30	0	0	0	0	0	0	0	11.77	0	0	11.2	0.1	1.1
2025	10	14	6	30	30	0	0	0	0	0	0	0	11.76	0	0	11.2	0.1	1.1
2025	10	14	6	40	30	0	0	0	0	0	0	0	11.75	0	0	11.2	0.1	1.1
2025	10	14	6	50	30	0	0	0	0	0	0	0	11.75	0	0	11.2	0.1	1.1
2025	10	14	7	0	30	0	0	0	0	0	0	0	11.74	0	0	11.2	0.1	1.1
2025	10	14	7	10	30	0	0	0	0	0	0	0	11.74	0	0	11.2	0.1	1.1
2025	10	14	7	20	30	0	0	0	0	0	0	0	11.73	0	0	11.2	0.1	1.1
2025	10	14	7	30	30	0	0	0	0	0	0	0	11.73	0	0	11.2	0.1	1.1
2025	10	14	7	40	30	0	0	0	0	0	0	0	11.71	0	0	11.2	0.1	1.1
2025	10	14	7	50	30	0	0	0	0	0	0	0	11.71	0	0	11.2	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	14	8	0	30	0	0	0	0	0	0	0	11.7	0	0	11.2	0.1	1.1
2025	10	14	8	10	30	0	0	0	0	0	0	0	11.69	0	0	11.2	0.1	1.1
2025	10	14	8	20	30	0	0	0	0	0	0	0	11.69	0	0	11.2	0.1	1.1
2025	10	14	8	30	30	0	0	0	0	0	0	0	11.68	0	0	11.2	0.1	1.1
2025	10	14	8	40	30	0	0	0	0	0	0	0	11.68	0	0	11.2	0.1	1.1
2025	10	14	8	50	30	0	0	0	0	0	0	0	11.66	0	0	11.2	0.1	1.1
2025	10	14	9	0	30	0	0	0	0	0	0	0	11.65	0	0	11.2	0.1	1.1
2025	10	14	9	10	30	0	0	0	0	0	0	0	11.64	0	0	11.2	0.1	1.1
2025	10	14	9	20	30	0	0	0	0	0	0	0	11.63	0	0	11.2	0.1	1.1
2025	10	14	9	30	30	0	0	0	0	0	0	0	11.62	0	0	11.2	0.1	1.1
2025	10	14	9	40	30	0	0	0	0	0	0	0	11.61	0	0	11.2	0.1	1.1
2025	10	14	9	50	30	0	0	0	0	0	0	0	11.61	0	0	11.2	0.1	1.1
2025	10	14	10	0	30	0	0	0	0	0	0	0	11.6	0	0	11.2	0.1	1.1
2025	10	14	10	10	30	0	0	0	0	0	0	0	11.6	0	0	11.2	0.1	1.1
2025	10	14	10	20	30	0	0	0	0	0	0	0	11.6	0	0	11.2	0.1	1.1
2025	10	14	10	30	30	0	0	0	0	0	0	0	11.58	0	0	11.2	0.1	1.1
2025	10	14	10	40	30	0	0	0	0	0	0	0	11.57	0	0	11.2	0.1	1.1
2025	10	14	10	50	30	0	0	0	0	0	0	0	11.56	0	0	11.2	0.1	1.1
2025	10	14	11	0	30	0	0	0	0	0	0	0	11.55	0	0	11.2	0.1	1.1
2025	10	14	11	10	30	0	0	0	0	0	0	0	11.56	0	0	11.4	0.1	1.1
2025	10	14	11	20	30	0	0	0	0	0	0	0	11.55	0	0	11.4	0.1	1.1
2025	10	14	11	30	30	0	0	0	0	0	0	0	11.53	0	0	11.2	0.1	1.1
2025	10	14	11	40	30	0	0	0	0	0	0	0	11.52	0	0	11.4	0.1	1.1
2025	10	14	11	50	30	0	0	0	0	0	0	0	11.51	0	0	11.4	0.1	1.1
2025	10	14	12	0	30	0	0	0	0	0	0	0	11.49	0	0	11.2	0.1	1.1
2025	10	14	12	10	30	0	0	0	0	0	0	0	11.47	0	0	11.2	0.1	1.1
2025	10	14	12	20	30	0	0	0	0	0	0	0	11.46	0	0	11.2	0.1	1.1
2025	10	14	12	30	30	0	0	0	0	0	0	0	11.45	0	0	11.2	0.1	1.2
2025	10	14	12	40	30	0	0	0	0	0	0	0	11.43	0	0	11.2	0.1	1.2
2025	10	14	12	50	30	0	0	0	0	0	0	0	11.42	0	0	11.2	0.1	1.2
2025	10	14	13	0	30	0	0	0	0	0	0	0	11.4	0	0	11.2	0.1	1.2
2025	10	14	13	10	30	0	0	0	0	0	0	0	11.38	0	0	11.2	0.1	1.2
2025	10	14	13	20	30	0	0	0	0	0	0	0	11.37	0	0	11.2	0.1	1.2
2025	10	14	13	30	30	0	0	0	0	0	0	0	11.36	0	0	11.2	0.1	1.2
2025	10	14	13	40	30	0	0	0	0	0	0	0	11.34	0	0	11.2	0.1	1.2
2025	10	14	13	50	30	0	0	0	0	0	0	0	11.32	0	0	11.2	0.1	1.2
2025	10	14	14	0	30	0	0	0	0	0	0	0	11.31	0	0	11.2	0.1	1.2
2025	10	14	14	10	30	0	0	0	0	0	0	0	11.29	0	0	11.2	0.1	1.2
2025	10	14	14	20	30	0	0	0	0	0	0	0	11.28	0	0	11.2	0.1	1.2
2025	10	14	14	30	30	0	0	0	0	0	0	0	11.32	0	0	11.8	0.1	1.2
2025	10	14	14	40	30	0	0	0	0	0	0	0	11.42	0	0	12.6	0.1	1.2
2025	10	14	14	50	30	0	0	0	0	0	0	0	11.42	0	0	12.6	0.1	1.2
2025	10	14	15	0	30	0	0	0	0	0	0	0	11.41	0	0	12.4	0.1	1.2
2025	10	14	15	10	30	0	0	0	0	0	0	0	11.38	0	0	12.4	0.1	1.2
2025	10	14	15	20	30	0	0	0	0	0	0	0	11.37	0	0	12.4	0.1	1.2
2025	10	14	15	30	30	0	0	0	0	0	0	0	11.36	0	0	12.4	0.1	1.2
2025	10	14	15	40	30	0	0	0	0	0	0	0	11.31	0	0	12.2	0.1	1.2
2025	10	14	15	50	30	0	0	0	0	0	0	0	11.31	0	0	12.2	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	14	16	0	30	0	0	0	0	0	0	0	11.28	0	0	12.2	0.1	1.2
2025	10	14	16	10	30	0	0	0	0	0	0	0	11.27	0	0	12.2	0.1	1.2
2025	10	14	16	20	30	0	0	0	0	0	0	0	11.25	0	0	12	0.1	1.2
2025	10	14	16	30	30	0	0	0	0	0	0	0	11.23	0	0	12	0.1	1.2
2025	10	14	16	40	30	0	0	0	0	0	0	0	11.2	0	0	12	0.1	1.2
2025	10	14	16	50	30	0	0	0	0	0	0	0	11.18	0	0	11.8	0.1	1.2
2025	10	14	17	0	30	0	0	0	0	0	0	0	11.16	0	0	11.8	0.1	1.2
2025	10	14	17	10	30	0	0	0	0	0	0	0	11.14	0	0	11.8	0.1	1.2
2025	10	14	17	20	30	0	0	0	0	0	0	0	11.13	0	0	11.6	0.1	1.2
2025	10	14	17	30	30	0	0	0	0	0	0	0	11.11	0	0	11.4	0.1	1.2
2025	10	14	17	40	30	0	0	0	0	0	0	0	11.1	0	0	11.4	0.1	1.2
2025	10	14	17	50	30	0	0	0	0	0	0	0	11.09	0	0	11.4	0.1	1.2
2025	10	14	18	0	30	0	0	0	0	0	0	0	11.07	0	0	11.4	0.1	1.2
2025	10	14	18	10	30	0	0	0	0	0	0	0	11.05	0	0	11.4	0.1	1.2
2025	10	14	18	20	30	0	0	0	0	0	0	0	11.03	0	0	11.4	0.1	1.2
2025	10	14	18	30	30	0	0	0	0	0	0	0	11.01	0	0	11.4	0.1	1.2
2025	10	14	18	40	30	0	0	0	0	0	0	0	10.99	0	0	11.4	0.1	1.2
2025	10	14	18	50	30	0	0	0	0	0	0	0	10.97	0	0	11.4	0.1	1.2
2025	10	14	19	0	30	0	0	0	0	0	0	0	10.95	0	0	11.4	0.1	1.2
2025	10	14	19	10	30	0	0	0	0	0	0	0	10.92	0	0	11.4	0.1	1.2
2025	10	14	19	20	30	0	0	0	0	0	0	0	10.9	0	0	11.2	0.1	1.2
2025	10	14	19	30	30	0	0	0	0	0	0	0	10.88	0	0	11.2	0.1	1.2
2025	10	14	19	40	30	0	0	0	0	0	0	0	10.86	0	0	11.2	0.1	1.2
2025	10	14	19	50	30	0	0	0	0	0	0	0	10.84	0	0	11.2	0.1	1.2
2025	10	14	20	0	30	0	0	0	0	0	0	0	10.83	0	0	11.2	0.1	1.2
2025	10	14	20	10	30	0	0	0	0	0	0	0	10.82	0	0	11.2	0.1	1.2
2025	10	14	20	20	30	0	0	0	0	0	0	0	10.8	0	0	11.2	0.1	1.2
2025	10	14	20	30	30	0	0	0	0	0	0	0	10.79	0	0	11.2	0.1	1.2
2025	10	14	20	40	30	0	0	0	0	0	0	0	10.78	0	0	11.2	0.1	1.2
2025	10	14	20	50	30	0	0	0	0	0	0	0	10.77	0	0	11.2	0.1	1.2
2025	10	14	21	0	30	0	0	0	0	0	0	0	10.76	0	0	11.2	0.1	1.2
2025	10	14	21	10	30	0	0	0	0	0	0	0	10.75	0	0	11.2	0.1	1.2
2025	10	14	21	20	30	0	0	0	0	0	0	0	10.74	0	0	11.2	0.1	1.2
2025	10	14	21	30	30	0	0	0	0	0	0	0	10.73	0	0	11.2	0.1	1.2
2025	10	14	21	40	30	0	0	0	0	0	0	0	10.73	0	0	11.2	0.1	1.2
2025	10	14	21	50	30	0	0	0	0	0	0	0	10.71	0	0	11.2	0.1	1.2
2025	10	14	22	0	30	0	0	0	0	0	0	0	10.7	0	0	11.2	0.1	1.2
2025	10	14	22	10	30	0	0	0	0	0	0	0	10.69	0	0	11.2	0.1	1.2
2025	10	14	22	20	30	0	0	0	0	0	0	0	10.69	0	0	11	0.1	1.2
2025	10	14	22	30	30	0	0	0	0	0	0	0	10.68	0	0	11	0.1	1.2
2025	10	14	22	40	30	0	0	0	0	0	0	0	10.67	0	0	11	0.1	1.2
2025	10	14	22	50	30	0	0	0	0	0	0	0	10.66	0	0	11	0.1	1.2
2025	10	14	23	0	30	0	0	0	0	0	0	0	10.64	0	0	11	0.1	1.2
2025	10	14	23	10	30	0	0	0	0	0	0	0	10.63	0	0	11	0.1	1.2
2025	10	14	23	20	30	0	0	0	0	0	0	0	10.62	0	0	11	0.1	1.2
2025	10	14	23	30	30	0	0	0	0	0	0	0	10.61	0	0	11	0.1	1.2
2025	10	14	23	40	30	0	0	0	0	0	0	0	10.6	0	0	11	0.1	1.2
2025	10	14	23	50	30	0	0	0	0	0	0	0	10.58	0	0	11	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	15	0	0	30	0	0	0	0	0	0	0	10.57	0	0	11	0.1	1.2
2025	10	15	0	10	30	0	0	0	0	0	0	0	10.56	0	0	11	0.1	1.2
2025	10	15	0	20	30	0	0	0	0	0	0	0	10.55	0	0	11	0.1	1.2
2025	10	15	0	30	30	0	0	0	0	0	0	0	10.54	0	0	11	0.1	1.2
2025	10	15	0	40	30	0	0	0	0	0	0	0	10.54	0	0	11	0.1	1.2
2025	10	15	0	50	30	0	0	0	0	0	0	0	10.53	0	0	11	0.1	1.2
2025	10	15	1	0	30	0	0	0	0	0	0	0	10.52	0	0	11	0.1	1.2
2025	10	15	1	10	30	0	0	0	0	0	0	0	10.51	0	0	11	0.1	1.2
2025	10	15	1	20	30	0	0	0	0	0	0	0	10.51	0	0	11	0.1	1.2
2025	10	15	1	30	30	0	0	0	0	0	0	0	10.5	0	0	11	0.1	1.2
2025	10	15	1	40	30	0	0	0	0	0	0	0	10.5	0	0	11	0.1	1.2
2025	10	15	1	50	30	0	0	0	0	0	0	0	10.49	0	0	11	0.1	1.2
2025	10	15	2	0	30	0	0	0	0	0	0	0	10.48	0	0	11	0.1	1.2
2025	10	15	2	10	30	0	0	0	0	0	0	0	10.47	0	0	11	0.1	1.2
2025	10	15	2	20	30	0	0	0	0	0	0	0	10.47	0	0	11	0.1	1.2
2025	10	15	2	30	30	0	0	0	0	0	0	0	10.46	0	0	11	0.1	1.2
2025	10	15	2	40	30	0	0	0	0	0	0	0	10.45	0	0	11	0.1	1.2
2025	10	15	2	50	30	0	0	0	0	0	0	0	10.44	0	0	11	0.1	1.2
2025	10	15	3	0	30	0	0	0	0	0	0	0	10.43	0	0	11	0.1	1.2
2025	10	15	3	10	30	0	0	0	0	0	0	0	10.42	0	0	11	0.1	1.2
2025	10	15	3	20	30	0	0	0	0	0	0	0	10.41	0	0	11	0.1	1.2
2025	10	15	3	30	30	0	0	0	0	0	0	0	10.4	0	0	11	0.1	1.2
2025	10	15	3	40	30	0	0	0	0	0	0	0	10.39	0	0	11	0.1	1.2
2025	10	15	3	50	30	0	0	0	0	0	0	0	10.38	0	0	11	0.1	1.2
2025	10	15	4	0	30	0	0	0	0	0	0	0	10.36	0	0	11	0.1	1.2
2025	10	15	4	10	30	0	0	0	0	0	0	0	10.35	0	0	11	0.1	1.2
2025	10	15	4	20	30	0	0	0	0	0	0	0	10.34	0	0	11	0.1	1.2
2025	10	15	4	30	30	0	0	0	0	0	0	0	10.33	0	0	11	0.1	1.2
2025	10	15	4	40	30	0	0	0	0	0	0	0	10.31	0	0	11	0.1	1.2
2025	10	15	4	50	30	0	0	0	0	0	0	0	10.29	0	0	11	0.1	1.2
2025	10	15	5	0	30	0	0	0	0	0	0	0	10.28	0	0	11	0.1	1.2
2025	10	15	5	10	30	0	0	0	0	0	0	0	10.26	0	0	11	0.1	1.2
2025	10	15	5	20	30	0	0	0	0	0	0	0	10.25	0	0	11	0.1	1.2
2025	10	15	5	30	30	0	0	0	0	0	0	0	10.22	0	0	11	0.1	1.2
2025	10	15	5	40	30	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1.2
2025	10	15	5	50	30	0	0	0	0	0	0	0	10.19	0	0	11	0.1	1.2
2025	10	15	6	0	30	0	0	0	0	0	0	0	10.17	0	0	11	0.1	1.2
2025	10	15	6	10	30	0	0	0	0	0	0	0	10.15	0	0	11	0.1	1.2
2025	10	15	6	20	30	0	0	0	0	0	0	0	10.13	0	0	11	0.1	1.2
2025	10	15	6	30	30	0	0	0	0	0	0	0	10.11	0	0	11	0.1	1.2
2025	10	15	6	40	30	0	0	0	0	0	0	0	10.08	0	0	11	0.1	1.2
2025	10	15	6	50	30	0	0	0	0	0	0	0	10.06	0	0	11	0.1	1.2
2025	10	15	7	0	30	0	0	0	0	0	0	0	10.05	0	0	11.2	0.1	1.2
2025	10	15	7	10	30	0	0	0	0	0	0	0	10.03	0	0	11.2	0.1	1.2
2025	10	15	7	20	30	0	0	0	0	0	0	0	10.01	0	0	11	0.1	1.2
2025	10	15	7	30	30	0	0	0	0	0	0	0	9.99	0	0	11	0.1	1.2
2025	10	15	7	40	30	0	0	0	0	0	0	0	9.98	0	0	11	0.1	1.2
2025	10	15	7	50	30	0	0	0	0	0	0	0	9.96	0	0	11.4	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	15	8	0	30	0	0	0	0	0	0	0	9.95	0	0	11.2	0.1	1.2
2025	10	15	8	10	30	0	0	0	0	0	0	0	9.94	0	0	11.6	0.1	1.2
2025	10	15	8	20	30	0	0	0	0	0	0	0	9.93	0	0	12	0.1	1.2
2025	10	15	8	30	30	0	0	0	0	0	0	0	9.92	0	0	12.2	0.1	1.2
2025	10	15	8	40	30	0	0	0	0	0	0	0	9.93	0	0	12.4	0.1	1.2
2025	10	15	8	50	30	0	0	0	0	0	0	0	9.97	0	0	12.6	0.1	1.2
2025	10	15	9	0	30	0	0	0	0	0	0	0	10	0	0	12.6	0.1	1.2
2025	10	15	9	10	30	0	0	0	0	0	0	0	10.01	0	0	12.6	0.1	1.2
2025	10	15	9	20	30	0	0	0	0	0	0	0	10.03	0	0	12.6	0.1	1.2
2025	10	15	9	30	30	0	0	0	0	0	0	0	10.05	0	0	12.6	0.1	1.2
2025	10	15	9	40	30	0	0	0	0	0	0	0	10.07	0	0	12.6	0.1	1.2
2025	10	15	9	50	30	0	0	0	0	0	0	0	10.09	0	0	12.6	0.1	1.2
2025	10	15	10	2	15	0	0	0	0	0	0	0	10.12	0	0	13	0.1	1.2
2025	10	15	10	12	15	0	0	0	0	0	0	0	10.14	0	0	13	0.1	1.2
2025	10	15	10	22	15	0	0	0	0	0	0	0	10.16	0	0	13	0.1	1.2
2025	10	15	10	32	15	0	0	0	0	0	0	0	10.19	0	0	13	0.1	1.2
2025	10	15	10	42	15	0	0	0	0	0	0	0	10.21	0	0	13.2	0.1	1.2
2025	10	15	10	52	15	0	0	0	0	0	0	0	10.23	0	0	13.2	0.1	1.2
2025	10	15	11	2	15	0	0	0	0	0	0	0	10.25	0	0	13.2	0.1	1.2
2025	10	15	11	12	15	0	0	0	0	0	0	0	10.28	0	0	13.4	0.1	1.2
2025	10	15	11	22	15	0	0	0	0	0	0	0	10.31	0	0	13.8	0.1	1.2
2025	10	15	11	32	15	0	0	0	0	0	0	0	10.33	0	0	13.8	0.1	1.2
2025	10	15	11	42	15	0	0	0	0	0	0	0	10.36	0	0	14	0.1	1.2
2025	10	15	11	52	15	0	0	0	0	0	0	0	10.38	0	0	13.8	0.1	1.2
2025	10	15	12	2	15	0	0	0	0	0	0	0	10.4	0	0	13.8	0.1	1.2
2025	10	15	12	12	15	0	0	0	0	0	0	0	10.42	0	0	14	0.1	1.2
2025	10	15	12	22	15	0	0	0	0	0	0	0	10.45	0	0	13.8	0.1	1.2
2025	10	15	12	32	15	0	0	0	0	0	0	0	10.46	0	0	13.8	0.1	1.2
2025	10	15	12	42	15	0	0	0	0	0	0	0	10.48	0	0	13.6	0.1	1.2
2025	10	15	12	52	15	0	0	0	0	0	0	0	10.5	0	0	13.6	0.1	1.2
2025	10	15	13	2	15	0	0	0	0	0	0	0	10.52	0	0	13.6	0.1	1.2
2025	10	15	13	12	15	0	0	0	0	0	0	0	10.54	0	0	13.6	0.1	1.2
2025	10	15	13	22	15	0	0	0	0	0	0	0	10.54	0	0	13.6	0.1	1.2
2025	10	15	13	32	15	0	0	0	0	0	0	0	10.56	0	0	13.6	0.1	1.2
2025	10	15	13	42	15	0	0	0	0	0	0	0	10.56	0	0	13.6	0.1	1.2
2025	10	15	13	52	15	0	0	0	0	0	0	0	10.58	0	0	13.6	0.1	1.2
2025	10	15	14	2	15	0	0	0	0	0	0	0	10.59	0	0	13.6	0.1	1.2
2025	10	15	14	12	15	0	0	0	0	0	0	0	10.6	0	0	13.2	0.1	1.2
2025	10	15	14	22	15	0	0	0	0	0	0	0	10.61	0	0	13.2	0.1	1.2
2025	10	15	14	32	15	0	0	0	0	0	0	0	10.61	0	0	13.2	0.1	1.2
2025	10	15	14	42	15	0	0	0	0	0	0	0	10.62	0	0	13.2	0.1	1.2
2025	10	15	14	52	15	0	0	0	0	0	0	0	10.62	0	0	13.2	0.1	1.2
2025	10	15	15	2	15	0	0	0	0	0	0	0	10.62	0	0	13.6	0.1	1.2
2025	10	15	15	12	15	0	0	0	0	0	0	0	10.63	0	0	13.6	0.1	1.2
2025	10	15	15	22	15	0	0	0	0	0	0	0	10.62	0	0	13.4	0.1	1.2
2025	10	15	15	32	15	0	0	0	0	0	0	0	10.63	0	0	13.4	0.1	1.2
2025	10	15	15	42	15	0	0	0	0	0	0	0	10.63	0	0	13.6	0.1	1.2
2025	10	15	15	52	15	0	0	0	0	0	0	0	10.62	0	0	13.6	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	15	16	2	15	0	0	0	0	0	0	0	10.59	0	0	13.6	0.1	1.2
2025	10	15	16	12	15	0	0	0	0	0	0	0	10.61	0	0	13.4	0.1	1.2
2025	10	15	16	22	15	0	0	0	0	0	0	0	10.59	0	0	12.8	0.1	1.2
2025	10	15	16	32	15	0	0	0	0	0	0	0	10.6	0	0	12.4	0.1	1.2
2025	10	15	16	42	15	0	0	0	0	0	0	0	10.59	0	0	12.2	0.1	1.2
2025	10	15	16	52	15	0	0	0	0	0	0	0	10.58	0	0	12	0.1	1.2
2025	10	15	17	2	15	0	0	0	0	0	0	0	10.57	0	0	12	0.1	1.2
2025	10	15	17	12	15	0	0	0	0	0	0	0	10.57	0	0	11.8	0.1	1.2
2025	10	15	17	22	15	0	0	0	0	0	0	0	10.57	0	0	11.6	0.1	1.2
2025	10	15	17	32	15	0	0	0	0	0	0	0	10.57	0	0	11.6	0.1	1.2
2025	10	15	17	42	15	0	0	0	0	0	0	0	10.57	0	0	11.6	0.1	1.2
2025	10	15	17	52	15	0	0	0	0	0	0	0	10.57	0	0	11.6	0.1	1.2
2025	10	15	18	2	15	0	0	0	0	0	0	0	10.56	0	0	11.4	0.1	1.2
2025	10	15	18	12	15	0	0	0	0	0	0	0	10.56	0	0	11.8	0.1	1.2
2025	10	15	18	22	15	0	0	0	0	0	0	0	10.55	0	0	11.8	0.1	1.2
2025	10	15	18	32	15	0	0	0	0	0	0	0	10.54	0	0	11.8	0.1	1.2
2025	10	15	18	42	15	0	0	0	0	0	0	0	10.53	0	0	11.8	0.1	1.2
2025	10	15	18	52	15	0	0	0	0	0	0	0	10.52	0	0	11.8	0.1	1.2
2025	10	15	19	2	15	0	0	0	0	0	0	0	10.51	0	0	11.8	0.1	1.2
2025	10	15	19	12	15	0	0	0	0	0	0	0	10.5	0	0	11.8	0.1	1.2
2025	10	15	19	22	15	0	0	0	0	0	0	0	10.49	0	0	11.8	0.1	1.2
2025	10	15	19	32	15	0	0	0	0	0	0	0	10.47	0	0	11.6	0.1	1.2
2025	10	15	19	42	15	0	0	0	0	0	0	0	10.46	0	0	11.8	0.1	1.2
2025	10	15	19	52	15	0	0	0	0	0	0	0	10.45	0	0	11.6	0.1	1.2
2025	10	15	20	2	15	0	0	0	0	0	0	0	10.44	0	0	11.4	0.1	1.2
2025	10	15	20	12	15	0	0	0	0	0	0	0	10.43	0	0	11.4	0.1	1.2
2025	10	15	20	22	15	0	0	0	0	0	0	0	10.41	0	0	11.6	0.1	1.2
2025	10	15	20	32	15	0	0	0	0	0	0	0	10.4	0	0	11.6	0.1	1.2
2025	10	15	20	42	15	0	0	0	0	0	0	0	10.4	0	0	11.6	0.1	1.2
2025	10	15	20	52	15	0	0	0	0	0	0	0	10.38	0	0	11.6	0.1	1.2
2025	10	15	21	2	15	0	0	0	0	0	0	0	10.37	0	0	11.6	0.1	1.2
2025	10	15	21	12	15	0	0	0	0	0	0	0	10.36	0	0	11.6	0.1	1.2
2025	10	15	21	22	15	0	0	0	0	0	0	0	10.35	0	0	11.6	0.1	1.2
2025	10	15	21	32	15	0	0	0	0	0	0	0	10.34	0	0	11.6	0.1	1.2
2025	10	15	21	42	15	0	0	0	0	0	0	0	10.33	0	0	11.6	0.1	1.2
2025	10	15	21	52	15	0	0	0	0	0	0	0	10.32	0	0	11.6	0.1	1.2
2025	10	15	22	2	15	0	0	0	0	0	0	0	10.31	0	0	11.6	0.1	1.2
2025	10	15	22	12	15	0	0	0	0	0	0	0	10.3	0	0	11.6	0.1	1.2
2025	10	15	22	22	15	0	0	0	0	0	0	0	10.29	0	0	11.6	0.1	1.2
2025	10	15	22	32	15	0	0	0	0	0	0	0	10.28	0	0	11.6	0.1	1.2
2025	10	15	22	42	15	0	0	0	0	0	0	0	10.27	0	0	11.6	0.1	1.2
2025	10	15	22	52	15	0	0	0	0	0	0	0	10.26	0	0	11.6	0.1	1.2
2025	10	15	23	2	15	0	0	0	0	0	0	0	10.26	0	0	11.6	0.1	1.2
2025	10	15	23	12	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1.2
2025	10	15	23	22	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1.2
2025	10	15	23	32	15	0	0	0	0	0	0	0	10.24	0	0	11.6	0.1	1.2
2025	10	15	23	42	15	0	0	0	0	0	0	0	10.23	0	0	11.6	0.1	1.2
2025	10	15	23	52	15	0	0	0	0	0	0	0	10.23	0	0	11.6	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	16	0	2	15	0	0	0	0	0	0	0	10.22	0	0	11.6	0.1	1.2
2025	10	16	0	12	15	0	0	0	0	0	0	0	10.22	0	0	11.6	0.1	1.2
2025	10	16	0	22	15	0	0	0	0	0	0	0	10.22	0	0	11.6	0.1	1.2
2025	10	16	0	32	15	0	0	0	0	0	0	0	10.21	0	0	11.6	0.1	1.2
2025	10	16	0	42	15	0	0	0	0	0	0	0	10.22	0	0	11.6	0.1	1.2
2025	10	16	0	52	15	0	0	0	0	0	0	0	10.21	0	0	11.6	0.1	1.2
2025	10	16	1	2	15	0	0	0	0	0	0	0	10.21	0	0	11.6	0.1	1.2
2025	10	16	1	12	15	0	0	0	0	0	0	0	10.21	0	0	11.6	0.1	1.2
2025	10	16	1	22	15	0	0	0	0	0	0	0	10.2	0	0	11.6	0.1	1.2
2025	10	16	1	32	15	0	0	0	0	0	0	0	10.21	0	0	11.6	0.1	1.2
2025	10	16	1	42	15	0	0	0	0	0	0	0	10.21	0	0	11.6	0.1	1.2
2025	10	16	1	52	15	0	0	0	0	0	0	0	10.21	0	0	11.6	0.1	1.2
2025	10	16	2	2	15	0	0	0	0	0	0	0	10.2	0	0	11.6	0.1	1.2
2025	10	16	2	12	15	0	0	0	0	0	0	0	10.21	0	0	11.6	0.1	1.2
2025	10	16	2	22	15	0	0	0	0	0	0	0	10.21	0	0	11.6	0.1	1.2
2025	10	16	2	32	15	0	0	0	0	0	0	0	10.21	0	0	11.6	0.1	1.2
2025	10	16	2	42	15	0	0	0	0	0	0	0	10.22	0	0	11.6	0.1	1.2
2025	10	16	2	52	15	0	0	0	0	0	0	0	10.22	0	0	11.6	0.1	1.2
2025	10	16	3	2	15	0	0	0	0	0	0	0	10.22	0	0	11.6	0.1	1.2
2025	10	16	3	12	15	0	0	0	0	0	0	0	10.23	0	0	11.6	0.1	1.2
2025	10	16	3	22	15	0	0	0	0	0	0	0	10.23	0	0	11.6	0.1	1.2
2025	10	16	3	32	15	0	0	0	0	0	0	0	10.24	0	0	11.6	0.1	1.2
2025	10	16	3	42	15	0	0	0	0	0	0	0	10.24	0	0	11.6	0.1	1.2
2025	10	16	3	52	15	0	0	0	0	0	0	0	10.24	0	0	11.6	0.1	1.2
2025	10	16	4	2	15	0	0	0	0	0	0	0	10.24	0	0	11.6	0.1	1.2
2025	10	16	4	12	15	0	0	0	0	0	0	0	10.24	0	0	11.6	0.1	1.2
2025	10	16	4	22	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1.2
2025	10	16	4	32	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1.2
2025	10	16	4	42	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1.2
2025	10	16	4	52	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1.2
2025	10	16	5	2	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1.2
2025	10	16	5	12	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1.2
2025	10	16	5	22	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1.2
2025	10	16	5	32	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1.2
2025	10	16	5	42	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1.2
2025	10	16	5	52	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1.2
2025	10	16	6	2	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1.2
2025	10	16	6	12	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1.2
2025	10	16	6	22	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1.2
2025	10	16	6	32	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1.2
2025	10	16	6	42	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1.2
2025	10	16	6	52	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1.2
2025	10	16	7	2	15	0	0	0	0	0	0	0	10.24	0	0	11.6	0.1	1.2
2025	10	16	7	12	15	0	0	0	0	0	0	0	10.24	0	0	11.6	0.1	1.2
2025	10	16	7	22	15	0	0	0	0	0	0	0	10.24	0	0	11.6	0.1	1.2
2025	10	16	7	32	15	0	0	0	0	0	0	0	10.24	0	0	11.6	0.1	1.2
2025	10	16	7	42	15	0	0	0	0	0	0	0	10.23	0	0	11.6	0.1	1.2
2025	10	16	7	52	15	0	0	0	0	0	0	0	10.23	0	0	11.8	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	16	8	2	15	0	0	0	0	0	0	0	10.22	0	0	12	0.1	1.2
2025	10	16	8	12	15	0	0	0	0	0	0	0	10.23	0	0	12.2	0.1	1.2
2025	10	16	8	22	15	0	0	0	0	0	0	0	10.22	0	0	12.4	0.1	1.2
2025	10	16	8	32	15	0	0	0	0	0	0	0	10.23	0	0	12.4	0.1	1.2
2025	10	16	8	42	15	0	0	0	0	0	0	0	10.24	0	0	12.4	0.1	1.2
2025	10	16	8	52	15	0	0	0	0	0	0	0	10.29	0	0	12.6	0.1	1.2
2025	10	16	9	2	15	0	0	0	0	0	0	0	10.31	0	0	12.6	0.1	1.2
2025	10	16	9	12	15	0	0	0	0	0	0	0	10.34	0	0	12.6	0.1	1.2
2025	10	16	9	22	15	0	0	0	0	0	0	0	10.37	0	0	12.8	0.1	1.2
2025	10	16	9	32	15	0	0	0	0	0	0	0	10.39	0	0	12.6	0.1	1.2
2025	10	16	9	42	15	0	0	0	0	0	0	0	10.41	0	0	12.8	0.1	1.2
2025	10	16	9	52	15	0	0	0	0	0	0	0	10.44	0	0	12.8	0.1	1.2
2025	10	16	10	2	15	0	0	0	0	0	0	0	10.46	0	0	13.4	0.1	1.2
2025	10	16	10	12	15	0	0	0	0	0	0	0	10.48	0	0	13.8	0.1	1.2
2025	10	16	10	22	15	0	0	0	0	0	0	0	10.5	0	0	13.6	0.1	1.2
2025	10	16	10	32	15	0	0	0	0	0	0	0	10.53	0	0	13.4	0.1	1.2
2025	10	16	10	42	15	0	0	0	0	0	0	0	10.55	0	0	13.2	0.1	1.2
2025	10	16	10	52	15	0	0	0	0	0	0	0	10.57	0	0	13.2	0.1	1.2
2025	10	16	11	2	15	0	0	0	0	0	0	0	10.59	0	0	13.2	0.1	1.2
2025	10	16	11	12	15	0	0	0	0	0	0	0	10.62	0	0	13.2	0.1	1.2
2025	10	16	11	22	15	0	0	0	0	0	0	0	10.64	0	0	13.6	0.1	1.2
2025	10	16	11	32	15	0	0	0	0	0	0	0	10.66	0	0	13.6	0.1	1.2
2025	10	16	11	42	15	0	0	0	0	0	0	0	10.68	0	0	13.6	0.1	1.2
2025	10	16	11	52	15	0	0	0	0	0	0	0	10.69	0	0	13.6	0.1	1.2
2025	10	16	12	2	15	0	0	0	0	0	0	0	10.72	0	0	13.6	0.1	1.2
2025	10	16	12	12	15	0	0	0	0	0	0	0	10.74	0	0	13.6	0.1	1.2
2025	10	16	12	22	15	0	0	0	0	0	0	0	10.75	0	0	13.6	0.1	1.2
2025	10	16	12	32	15	0	0	0	0	0	0	0	10.77	0	0	13.6	0.1	1.2
2025	10	16	12	42	15	0	0	0	0	0	0	0	10.78	0	0	13.6	0.1	1.2
2025	10	16	12	52	15	0	0	0	0	0	0	0	10.79	0	0	13.6	0.1	1.2
2025	10	16	13	2	15	0	0	0	0	0	0	0	10.8	0	0	13.6	0.1	1.2
2025	10	16	13	12	15	0	0	0	0	0	0	0	10.81	0	0	13.6	0.1	1.2
2025	10	16	13	22	15	0	0	0	0	0	0	0	10.82	0	0	13.4	0.1	1.2
2025	10	16	13	32	15	0	0	0	0	0	0	0	10.82	0	0	13.4	0.1	1.2
2025	10	16	13	42	15	0	0	0	0	0	0	0	10.82	0	0	13.4	0.1	1.2
2025	10	16	13	52	15	0	0	0	0	0	0	0	10.84	0	0	13.4	0.1	1.2
2025	10	16	14	2	15	0	0	0	0	0	0	0	10.84	0	0	13.4	0.1	1.2
2025	10	16	14	12	15	0	0	0	0	0	0	0	10.83	0	0	13.8	0.1	1.2
2025	10	16	14	22	15	0	0	0	0	0	0	0	10.84	0	0	13.6	0.1	1.2
2025	10	16	14	32	15	0	0	0	0	0	0	0	10.83	0	0	13.6	0.1	1.2
2025	10	16	14	42	15	0	0	0	0	0	0	0	10.82	0	0	13.6	0.1	1.2
2025	10	16	14	52	15	0	0	0	0	0	0	0	10.81	0	0	13.6	0.1	1.2
2025	10	16	15	2	15	0	0	0	0	0	0	0	10.82	0	0	13.6	0.1	1.2
2025	10	16	15	12	15	0	0	0	0	0	0	0	10.8	0	0	13.4	0.1	1.2
2025	10	16	15	22	15	0	0	0	0	0	0	0	10.79	0	0	13.4	0.1	1.2
2025	10	16	15	32	15	0	0	0	0	0	0	0	10.78	0	0	13.4	0.1	1.2
2025	10	16	15	42	15	0	0	0	0	0	0	0	10.76	0	0	13.4	0.1	1.2
2025	10	16	15	52	15	0	0	0	0	0	0	0	10.75	0	0	13.4	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	16	16	2	15	0	0	0	0	0	0	0	10.71	0	0	13.4	0.1	1.2
2025	10	16	16	12	15	0	0	0	0	0	0	0	10.71	0	0	13.4	0.1	1.2
2025	10	16	16	22	15	0	0	0	0	0	0	0	10.68	0	0	13.4	0.1	1.2
2025	10	16	16	32	15	0	0	0	0	0	0	0	10.68	0	0	13	0.1	1.2
2025	10	16	16	42	15	0	0	0	0	0	0	0	10.67	0	0	12.2	0.1	1.2
2025	10	16	16	52	15	0	0	0	0	0	0	0	10.63	0	0	12.2	0.1	1.2
2025	10	16	17	2	15	0	0	0	0	0	0	0	10.62	0	0	12	0.1	1.2
2025	10	16	17	12	15	0	0	0	0	0	0	0	10.6	0	0	11.8	0.1	1.2
2025	10	16	17	22	15	0	0	0	0	0	0	0	10.59	0	0	11.6	0.1	1.2
2025	10	16	17	32	15	0	0	0	0	0	0	0	10.58	0	0	11.6	0.1	1.2
2025	10	16	17	42	15	0	0	0	0	0	0	0	10.56	0	0	11.4	0.1	1.2
2025	10	16	17	52	15	0	0	0	0	0	0	0	10.55	0	0	11.8	0.1	1.2
2025	10	16	18	2	15	0	0	0	0	0	0	0	10.53	0	0	11.4	0.1	1.2
2025	10	16	18	12	15	0	0	0	0	0	0	0	10.52	0	0	11.6	0.1	1.2
2025	10	16	18	22	15	0	0	0	0	0	0	0	10.5	0	0	11.6	0.1	1.2
2025	10	16	18	32	15	0	0	0	0	0	0	0	10.48	0	0	11.4	0.1	1.2
2025	10	16	18	42	15	0	0	0	0	0	0	0	10.46	0	0	11.4	0.1	1.2
2025	10	16	18	52	15	0	0	0	0	0	0	0	10.43	0	0	11.4	0.1	1.2
2025	10	16	19	2	15	0	0	0	0	0	0	0	10.41	0	0	11.8	0.1	1.2
2025	10	16	19	12	15	0	0	0	0	0	0	0	10.39	0	0	11.8	0.1	1.2
2025	10	16	19	22	15	0	0	0	0	0	0	0	10.37	0	0	11.8	0.1	1.2
2025	10	16	19	32	15	0	0	0	0	0	0	0	10.36	0	0	11.4	0.1	1.2
2025	10	16	19	42	15	0	0	0	0	0	0	0	10.33	0	0	11.4	0.1	1.2
2025	10	16	19	52	15	0	0	0	0	0	0	0	10.31	0	0	11.4	0.1	1.2
2025	10	16	20	2	15	0	0	0	0	0	0	0	10.29	0	0	11.4	0.1	1.2
2025	10	16	20	12	15	0	0	0	0	0	0	0	10.27	0	0	11.4	0.1	1.2
2025	10	16	20	22	15	0	0	0	0	0	0	0	10.26	0	0	11.4	0.1	1.2
2025	10	16	20	32	15	0	0	0	0	0	0	0	10.24	0	0	11.4	0.1	1.2
2025	10	16	20	42	15	0	0	0	0	0	0	0	10.22	0	0	11.4	0.1	1.2
2025	10	16	20	52	15	0	0	0	0	0	0	0	10.2	0	0	11.4	0.1	1.2
2025	10	16	21	2	15	0	0	0	0	0	0	0	10.18	0	0	11.4	0.1	1.2
2025	10	16	21	12	15	0	0	0	0	0	0	0	10.17	0	0	11.4	0.1	1.2
2025	10	16	21	22	15	0	0	0	0	0	0	0	10.17	0	0	11.2	0.1	1.2
2025	10	16	21	32	15	0	0	0	0	0	0	0	10.15	0	0	11.2	0.1	1.2
2025	10	16	21	42	15	0	0	0	0	0	0	0	10.15	0	0	11.2	0.1	1.2
2025	10	16	21	52	15	0	0	0	0	0	0	0	10.14	0	0	11.2	0.1	1.2
2025	10	16	22	2	15	0	0	0	0	0	0	0	10.12	0	0	11.2	0.1	1.2
2025	10	16	22	12	15	0	0	0	0	0	0	0	10.11	0	0	11.2	0.1	1.2
2025	10	16	22	22	15	0	0	0	0	0	0	0	10.1	0	0	11.2	0.1	1.2
2025	10	16	22	32	15	0	0	0	0	0	0	0	10.09	0	0	11.2	0.1	1.2
2025	10	16	22	42	15	0	0	0	0	0	0	0	10.08	0	0	11.2	0.1	1.2
2025	10	16	22	52	15	0	0	0	0	0	0	0	10.07	0	0	11.2	0.1	1.2
2025	10	16	23	2	15	0	0	0	0	0	0	0	10.06	0	0	11.2	0.1	1.2
2025	10	16	23	12	15	0	0	0	0	0	0	0	10.06	0	0	11.2	0.1	1.2
2025	10	16	23	22	15	0	0	0	0	0	0	0	10.05	0	0	11.2	0.1	1.2
2025	10	16	23	32	15	0	0	0	0	0	0	0	10.04	0	0	11.2	0.1	1.2
2025	10	16	23	42	15	0	0	0	0	0	0	0	10.04	0	0	11.2	0.1	1.2
2025	10	16	23	52	15	0	0	0	0	0	0	0	10.03	0	0	11.2	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	17	0	2	15	0	0	0	0	0	0	0	10.03	0	0	11.2	0.1	1.2
2025	10	17	0	12	15	0	0	0	0	0	0	0	10.03	0	0	11.2	0.1	1.2
2025	10	17	0	22	15	0	0	0	0	0	0	0	10.03	0	0	11.2	0.1	1.2
2025	10	17	0	32	15	0	0	0	0	0	0	0	10.03	0	0	11.2	0.1	1.2
2025	10	17	0	42	15	0	0	0	0	0	0	0	10.04	0	0	11.2	0.1	1.2
2025	10	17	0	52	15	0	0	0	0	0	0	0	10.04	0	0	11.2	0.1	1.2
2025	10	17	1	2	15	0	0	0	0	0	0	0	10.05	0	0	11.2	0.1	1.2
2025	10	17	1	12	15	0	0	0	0	0	0	0	10.05	0	0	11.2	0.1	1.2
2025	10	17	1	22	15	0	0	0	0	0	0	0	10.06	0	0	11.2	0.1	1.2
2025	10	17	1	32	15	0	0	0	0	0	0	0	10.07	0	0	11.2	0.1	1.2
2025	10	17	1	42	15	0	0	0	0	0	0	0	10.07	0	0	11.2	0.1	1.2
2025	10	17	1	52	15	0	0	0	0	0	0	0	10.08	0	0	11.2	0.1	1.2
2025	10	17	2	2	15	0	0	0	0	0	0	0	10.09	0	0	11.2	0.1	1.2
2025	10	17	2	12	15	0	0	0	0	0	0	0	10.1	0	0	11.2	0.1	1.2
2025	10	17	2	22	15	0	0	0	0	0	0	0	10.11	0	0	11.2	0.1	1.2
2025	10	17	2	32	15	0	0	0	0	0	0	0	10.12	0	0	11.2	0.1	1.2
2025	10	17	2	42	15	0	0	0	0	0	0	0	10.13	0	0	11.2	0.1	1.2
2025	10	17	2	52	15	0	0	0	0	0	0	0	10.14	0	0	11.2	0.1	1.2
2025	10	17	3	2	15	0	0	0	0	0	0	0	10.15	0	0	11.2	0.1	1.2
2025	10	17	3	12	15	0	0	0	0	0	0	0	10.16	0	0	11.2	0.1	1.2
2025	10	17	3	22	15	0	0	0	0	0	0	0	10.17	0	0	11.2	0.1	1.2
2025	10	17	3	32	15	0	0	0	0	0	0	0	10.17	0	0	11.2	0.1	1.2
2025	10	17	3	42	15	0	0	0	0	0	0	0	10.18	0	0	11.2	0.1	1.2
2025	10	17	3	52	15	0	0	0	0	0	0	0	10.19	0	0	11.2	0.1	1.2
2025	10	17	4	2	15	0	0	0	0	0	0	0	10.2	0	0	11.2	0.1	1.2
2025	10	17	4	12	15	0	0	0	0	0	0	0	10.2	0	0	11.2	0.1	1.2
2025	10	17	4	22	15	0	0	0	0	0	0	0	10.21	0	0	11.2	0.1	1.2
2025	10	17	4	32	15	0	0	0	0	0	0	0	10.22	0	0	11.2	0.1	1.2
2025	10	17	4	42	15	0	0	0	0	0	0	0	10.23	0	0	11.2	0.1	1.2
2025	10	17	4	52	15	0	0	0	0	0	0	0	10.23	0	0	11.2	0.1	1.2
2025	10	17	5	2	15	0	0	0	0	0	0	0	10.23	0	0	11.2	0.1	1.2
2025	10	17	5	12	15	0	0	0	0	0	0	0	10.24	0	0	11.2	0.1	1.2
2025	10	17	5	22	15	0	0	0	0	0	0	0	10.24	0	0	11.2	0.1	1.2
2025	10	17	5	32	15	0	0	0	0	0	0	0	10.24	0	0	11.2	0.1	1.2
2025	10	17	5	42	15	0	0	0	0	0	0	0	10.25	0	0	11.2	0.1	1.2
2025	10	17	5	52	15	0	0	0	0	0	0	0	10.25	0	0	11.2	0.1	1.2
2025	10	17	6	2	15	0	0	0	0	0	0	0	10.25	0	0	11.2	0.1	1.2
2025	10	17	6	12	15	0	0	0	0	0	0	0	10.25	0	0	11.2	0.1	1.2
2025	10	17	6	22	15	0	0	0	0	0	0	0	10.26	0	0	11.2	0.1	1.2
2025	10	17	6	32	15	0	0	0	0	0	0	0	10.25	0	0	11.2	0.1	1.2
2025	10	17	6	42	15	0	0	0	0	0	0	0	10.25	0	0	11.2	0.1	1.2
2025	10	17	6	52	15	0	0	0	0	0	0	0	10.25	0	0	11.2	0.1	1.2
2025	10	17	7	2	15	0	0	0	0	0	0	0	10.25	0	0	11.2	0.1	1.2
2025	10	17	7	12	15	0	0	0	0	0	0	0	10.25	0	0	11.2	0.1	1.2
2025	10	17	7	22	15	0	0	0	0	0	0	0	10.25	0	0	11.2	0.1	1.2
2025	10	17	7	32	15	0	0	0	0	0	0	0	10.24	0	0	11.2	0.1	1.2
2025	10	17	7	42	15	0	0	0	0	0	0	0	10.23	0	0	11.2	0.1	1.2
2025	10	17	7	52	15	0	0	0	0	0	0	0	10.23	0	0	11.4	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	17	8	2	15	0	0	0	0	0	0	0	10.23	0	0	11.6	0.1	1.2
2025	10	17	8	12	15	0	0	0	0	0	0	0	10.23	0	0	11.8	0.1	1.2
2025	10	17	8	22	15	0	0	0	0	0	0	0	10.23	0	0	12	0.1	1.2
2025	10	17	8	32	15	0	0	0	0	0	0	0	10.22	0	0	12	0.1	1.2
2025	10	17	8	42	15	0	0	0	0	0	0	0	10.23	0	0	12.2	0.1	1.2
2025	10	17	8	52	15	0	0	0	0	0	0	0	10.29	0	0	12.2	0.1	1.2
2025	10	17	9	2	15	0	0	0	0	0	0	0	10.32	0	0	12.2	0.1	1.2
2025	10	17	9	12	15	0	0	0	0	0	0	0	10.34	0	0	12.4	0.1	1.2
2025	10	17	9	22	15	0	0	0	0	0	0	0	10.36	0	0	12.4	0.1	1.2
2025	10	17	9	32	15	0	0	0	0	0	0	0	10.38	0	0	12.6	0.1	1.2
2025	10	17	9	42	15	0	0	0	0	0	0	0	10.39	0	0	12.6	0.1	1.2
2025	10	17	9	52	15	0	0	0	0	0	0	0	10.42	0	0	12.8	0.1	1.2
2025	10	17	10	2	15	0	0	0	0	0	0	0	10.45	0	0	13.4	0.1	1.2
2025	10	17	10	12	15	0	0	0	0	0	0	0	10.47	0	0	13.6	0.1	1.2
2025	10	17	10	22	15	0	0	0	0	0	0	0	10.49	0	0	13.6	0.1	1.2
2025	10	17	10	32	15	0	0	0	0	0	0	0	10.51	0	0	13.6	0.1	1.2
2025	10	17	10	42	15	0	0	0	0	0	0	0	10.53	0	0	13.6	0.1	1.2
2025	10	17	10	52	15	0	0	0	0	0	0	0	10.56	0	0	13.6	0.1	1.2
2025	10	17	11	2	15	0	0	0	0	0	0	0	10.57	0	0	13.6	0.1	1.2
2025	10	17	11	12	15	0	0	0	0	0	0	0	10.59	0	0	13.6	0.1	1.2
2025	10	17	11	22	15	0	0	0	0	0	0	0	10.61	0	0	13.6	0.1	1.2
2025	10	17	11	32	15	0	0	0	0	0	0	0	10.62	0	0	13.6	0.1	1.2
2025	10	17	11	42	15	0	0	0	0	0	0	0	10.64	0	0	13.6	0.1	1.2
2025	10	17	11	52	15	0	0	0	0	0	0	0	10.65	0	0	13.4	0.1	1.2
2025	10	17	12	2	15	0	0	0	0	0	0	0	10.67	0	0	13.4	0.1	1.2
2025	10	17	12	12	15	0	0	0	0	0	0	0	10.7	0	0	13.4	0.1	1.2
2025	10	17	12	22	15	0	0	0	0	0	0	0	10.71	0	0	13.4	0.1	1.2
2025	10	17	12	32	15	0	0	0	0	0	0	0	10.71	0	0	13.4	0.1	1.2
2025	10	17	12	42	15	0	0	0	0	0	0	0	10.73	0	0	13.4	0.1	1.2
2025	10	17	12	52	15	0	0	0	0	0	0	0	10.74	0	0	13.4	0.1	1.2
2025	10	17	13	2	15	0	0	0	0	0	0	0	10.75	0	0	13.4	0.1	1.2
2025	10	17	13	12	15	0	0	0	0	0	0	0	10.75	0	0	13.4	0.1	1.2
2025	10	17	13	22	15	0	0	0	0	0	0	0	10.76	0	0	13.6	0.1	1.2
2025	10	17	13	32	15	0	0	0	0	0	0	0	10.76	0	0	13.6	0.1	1.2
2025	10	17	13	42	15	0	0	0	0	0	0	0	10.76	0	0	13.6	0.1	1.2
2025	10	17	13	52	15	0	0	0	0	0	0	0	10.76	0	0	13.6	0.1	1.2
2025	10	17	14	2	15	0	0	0	0	0	0	0	10.77	0	0	13.6	0.1	1.2
2025	10	17	14	12	15	0	0	0	0	0	0	0	10.76	0	0	13.6	0.1	1.2
2025	10	17	14	22	15	0	0	0	0	0	0	0	10.76	0	0	13.6	0.1	1.2
2025	10	17	14	32	15	0	0	0	0	0	0	0	10.75	0	0	13.4	0.1	1.2
2025	10	17	14	42	15	0	0	0	0	0	0	0	10.75	0	0	13.4	0.1	1.2
2025	10	17	14	52	15	0	0	0	0	0	0	0	10.75	0	0	13.6	0.1	1.2
2025	10	17	15	2	15	0	0	0	0	0	0	0	10.74	0	0	13.6	0.1	1.2
2025	10	17	15	12	15	0	0	0	0	0	0	0	10.73	0	0	13.4	0.1	1.2
2025	10	17	15	22	15	0	0	0	0	0	0	0	10.72	0	0	13.4	0.1	1.2
2025	10	17	15	32	15	0	0	0	0	0	0	0	10.71	0	0	13.4	0.1	1.2
2025	10	17	15	42	15	0	0	0	0	0	0	0	10.7	0	0	13.4	0.1	1.2
2025	10	17	15	52	15	0	0	0	0	0	0	0	10.69	0	0	13.4	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	17	16	2	15	0	0	0	0	0	0	0	10.65	0	0	13.4	0.1	1.2
2025	10	17	16	12	15	0	0	0	0	0	0	0	10.66	0	0	13.4	0.1	1.2
2025	10	17	16	22	15	0	0	0	0	0	0	0	10.63	0	0	13.4	0.1	1.2
2025	10	17	16	32	15	0	0	0	0	0	0	0	10.61	0	0	13.2	0.1	1.2
2025	10	17	16	42	15	0	0	0	0	0	0	0	10.62	0	0	12.4	0.1	1.2
2025	10	17	16	52	15	0	0	0	0	0	0	0	10.59	0	0	12.2	0.1	1.2
2025	10	17	17	2	15	0	0	0	0	0	0	0	10.58	0	0	12.2	0.1	1.2
2025	10	17	17	12	15	0	0	0	0	0	0	0	10.56	0	0	12	0.1	1.2
2025	10	17	17	22	15	0	0	0	0	0	0	0	10.56	0	0	11.8	0.1	1.2
2025	10	17	17	32	15	0	0	0	0	0	0	0	10.55	0	0	11.6	0.1	1.2
2025	10	17	17	42	15	0	0	0	0	0	0	0	10.55	0	0	11.6	0.1	1.2
2025	10	17	17	52	15	0	0	0	0	0	0	0	10.53	0	0	11.6	0.1	1.2
2025	10	17	18	2	15	0	0	0	0	0	0	0	10.53	0	0	11.6	0.1	1.2
2025	10	17	18	12	15	0	0	0	0	0	0	0	10.52	0	0	11.6	0.1	1.2
2025	10	17	18	22	15	0	0	0	0	0	0	0	10.5	0	0	11.8	0.1	1.2
2025	10	17	18	32	15	0	0	0	0	0	0	0	10.49	0	0	11.6	0.1	1.2
2025	10	17	18	42	15	0	0	0	0	0	0	0	10.47	0	0	11.6	0.1	1.2
2025	10	17	18	52	15	0	0	0	0	0	0	0	10.46	0	0	11.6	0.1	1.2
2025	10	17	19	2	15	0	0	0	0	0	0	0	10.44	0	0	11.6	0.1	1.2
2025	10	17	19	12	15	0	0	0	0	0	0	0	10.43	0	0	11.6	0.1	1.2
2025	10	17	19	22	15	0	0	0	0	0	0	0	10.41	0	0	11.6	0.1	1.2
2025	10	17	19	32	15	0	0	0	0	0	0	0	10.39	0	0	11.6	0.1	1.2
2025	10	17	19	42	15	0	0	0	0	0	0	0	10.38	0	0	11.6	0.1	1.2
2025	10	17	19	52	15	0	0	0	0	0	0	0	10.36	0	0	11.6	0.1	1.2
2025	10	17	20	2	15	0	0	0	0	0	0	0	10.34	0	0	11.6	0.1	1.2
2025	10	17	20	12	15	0	0	0	0	0	0	0	10.32	0	0	11.6	0.1	1.2
2025	10	17	20	22	15	0	0	0	0	0	0	0	10.3	0	0	11.6	0.1	1.2
2025	10	17	20	32	15	0	0	0	0	0	0	0	10.29	0	0	11.6	0.1	1.2
2025	10	17	20	42	15	0	0	0	0	0	0	0	10.27	0	0	11.6	0.1	1.2
2025	10	17	20	52	15	0	0	0	0	0	0	0	10.26	0	0	11.6	0.1	1.2
2025	10	17	21	2	15	0	0	0	0	0	0	0	10.24	0	0	11.6	0.1	1.2
2025	10	17	21	12	15	0	0	0	0	0	0	0	10.23	0	0	11.6	0.1	1.2
2025	10	17	21	22	15	0	0	0	0	0	0	0	10.22	0	0	11.6	0.1	1.2
2025	10	17	21	32	15	0	0	0	0	0	0	0	10.2	0	0	11.4	0.1	1.2
2025	10	17	21	42	15	0	0	0	0	0	0	0	10.19	0	0	11.4	0.1	1.2
2025	10	17	21	52	15	0	0	0	0	0	0	0	10.18	0	0	11.4	0.1	1.2
2025	10	17	22	2	15	0	0	0	0	0	0	0	10.17	0	0	11.4	0.1	1.2
2025	10	17	22	12	15	0	0	0	0	0	0	0	10.16	0	0	11.4	0.1	1.2
2025	10	17	22	22	15	0	0	0	0	0	0	0	10.15	0	0	11.4	0.1	1.2
2025	10	17	22	32	15	0	0	0	0	0	0	0	10.14	0	0	11.4	0.1	1.2
2025	10	17	22	42	15	0	0	0	0	0	0	0	10.13	0	0	11.4	0.1	1.2
2025	10	17	22	52	15	0	0	0	0	0	0	0	10.12	0	0	11.4	0.1	1.2
2025	10	17	23	2	15	0	0	0	0	0	0	0	10.11	0	0	11.4	0.1	1.2
2025	10	17	23	12	15	0	0	0	0	0	0	0	10.11	0	0	11.4	0.1	1.2
2025	10	17	23	22	15	0	0	0	0	0	0	0	10.1	0	0	11.4	0.1	1.2
2025	10	17	23	32	15	0	0	0	0	0	0	0	10.09	0	0	11.4	0.1	1.2
2025	10	17	23	42	15	0	0	0	0	0	0	0	10.09	0	0	11.4	0.1	1.2
2025	10	17	23	52	15	0	0	0	0	0	0	0	10.08	0	0	11.4	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	18	0	2	15	0	0	0	0	0	0	0	10.08	0	0	11.4	0.1	1.2
2025	10	18	0	12	15	0	0	0	0	0	0	0	10.07	0	0	11.4	0.1	1.2
2025	10	18	0	22	15	0	0	0	0	0	0	0	10.07	0	0	11.4	0.1	1.2
2025	10	18	0	32	15	0	0	0	0	0	0	0	10.07	0	0	11.4	0.1	1.2
2025	10	18	0	42	15	0	0	0	0	0	0	0	10.07	0	0	11.4	0.1	1.2
2025	10	18	0	52	15	0	0	0	0	0	0	0	10.06	0	0	11.4	0.1	1.2
2025	10	18	1	2	15	0	0	0	0	0	0	0	10.07	0	0	11.4	0.1	1.2
2025	10	18	1	12	15	0	0	0	0	0	0	0	10.07	0	0	11.4	0.1	1.2
2025	10	18	1	22	15	0	0	0	0	0	0	0	10.06	0	0	11.4	0.1	1.2
2025	10	18	1	32	15	0	0	0	0	0	0	0	10.06	0	0	11.4	0.1	1.2
2025	10	18	1	42	15	0	0	0	0	0	0	0	10.06	0	0	11.4	0.1	1.2
2025	10	18	1	52	15	0	0	0	0	0	0	0	10.06	0	0	11.4	0.1	1.2
2025	10	18	2	2	15	0	0	0	0	0	0	0	10.07	0	0	11.4	0.1	1.2
2025	10	18	2	12	15	0	0	0	0	0	0	0	10.07	0	0	11.4	0.1	1.2
2025	10	18	2	22	15	0	0	0	0	0	0	0	10.08	0	0	11.4	0.1	1.2
2025	10	18	2	32	15	0	0	0	0	0	0	0	10.08	0	0	11.4	0.1	1.2
2025	10	18	2	42	15	0	0	0	0	0	0	0	10.08	0	0	11.4	0.1	1.2
2025	10	18	2	52	15	0	0	0	0	0	0	0	10.08	0	0	11.4	0.1	1.2
2025	10	18	3	2	15	0	0	0	0	0	0	0	10.09	0	0	11.4	0.1	1.2
2025	10	18	3	12	15	0	0	0	0	0	0	0	10.09	0	0	11.4	0.1	1.2
2025	10	18	3	22	15	0	0	0	0	0	0	0	10.09	0	0	11.4	0.1	1.2
2025	10	18	3	32	15	0	0	0	0	0	0	0	10.1	0	0	11.4	0.1	1.2
2025	10	18	3	42	15	0	0	0	0	0	0	0	10.1	0	0	11.4	0.1	1.2
2025	10	18	3	52	15	0	0	0	0	0	0	0	10.1	0	0	11.4	0.1	1.2
2025	10	18	4	2	15	0	0	0	0	0	0	0	10.1	0	0	11.4	0.1	1.2
2025	10	18	4	12	15	0	0	0	0	0	0	0	10.1	0	0	11.4	0.1	1.2
2025	10	18	4	22	15	0	0	0	0	0	0	0	10.1	0	0	11.4	0.1	1.2
2025	10	18	4	32	15	0	0	0	0	0	0	0	10.1	0	0	11.4	0.1	1.2
2025	10	18	4	42	15	0	0	0	0	0	0	0	10.1	0	0	11.4	0.1	1.2
2025	10	18	4	52	15	0	0	0	0	0	0	0	10.1	0	0	11.4	0.1	1.2
2025	10	18	5	2	15	0	0	0	0	0	0	0	10.1	0	0	11.4	0.1	1.2
2025	10	18	5	12	15	0	0	0	0	0	0	0	10.1	0	0	11.4	0.1	1.2
2025	10	18	5	22	15	0	0	0	0	0	0	0	10.1	0	0	11.4	0.1	1.2
2025	10	18	5	32	15	0	0	0	0	0	0	0	10.09	0	0	11.4	0.1	1.2
2025	10	18	5	42	15	0	0	0	0	0	0	0	10.09	0	0	11.4	0.1	1.2
2025	10	18	5	52	15	0	0	0	0	0	0	0	10.09	0	0	11.4	0.1	1.2
2025	10	18	6	2	15	0	0	0	0	0	0	0	10.08	0	0	11.4	0.1	1.2
2025	10	18	6	12	15	0	0	0	0	0	0	0	10.08	0	0	11.4	0.1	1.2
2025	10	18	6	22	15	0	0	0	0	0	0	0	10.07	0	0	11.4	0.1	1.2
2025	10	18	6	32	15	0	0	0	0	0	0	0	10.06	0	0	11.4	0.1	1.2
2025	10	18	6	42	15	0	0	0	0	0	0	0	10.07	0	0	11.4	0.1	1.2
2025	10	18	6	52	15	0	0	0	0	0	0	0	10.06	0	0	11.4	0.1	1.2
2025	10	18	7	2	15	0	0	0	0	0	0	0	10.05	0	0	11.4	0.1	1.2
2025	10	18	7	12	15	0	0	0	0	0	0	0	10.04	0	0	11.4	0.1	1.2
2025	10	18	7	22	15	0	0	0	0	0	0	0	10.04	0	0	11.4	0.1	1.2
2025	10	18	7	32	15	0	0	0	0	0	0	0	10.03	0	0	11.4	0.1	1.2
2025	10	18	7	42	15	0	0	0	0	0	0	0	10.03	0	0	11.4	0.1	1.2
2025	10	18	7	52	15	0	0	0	0	0	0	0	10.02	0	0	11.6	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	18	8	2	15	0	0	0	0	0	0	0	10.01	0	0	11.8	0.1	1.2
2025	10	18	8	12	15	0	0	0	0	0	0	0	10.01	0	0	12	0.1	1.2
2025	10	18	8	22	15	0	0	0	0	0	0	0	10	0	0	12.2	0.1	1.2
2025	10	18	8	32	15	0	0	0	0	0	0	0	10.01	0	0	12.4	0.1	1.2
2025	10	18	8	42	15	0	0	0	0	0	0	0	10.01	0	0	12.4	0.1	1.2
2025	10	18	8	52	15	0	0	0	0	0	0	0	10.08	0	0	12.6	0.1	1.2
2025	10	18	9	2	15	0	0	0	0	0	0	0	10.1	0	0	12.6	0.1	1.2
2025	10	18	9	12	15	0	0	0	0	0	0	0	10.13	0	0	12.6	0.1	1.2
2025	10	18	9	22	15	0	0	0	0	0	0	0	10.15	0	0	12.8	0.1	1.2
2025	10	18	9	32	15	0	0	0	0	0	0	0	10.17	0	0	12.8	0.1	1.2
2025	10	18	9	42	15	0	0	0	0	0	0	0	10.19	0	0	13	0.1	1.2
2025	10	18	9	52	15	0	0	0	0	0	0	0	10.22	0	0	13.2	0.1	1.2
2025	10	18	10	2	15	0	0	0	0	0	0	0	10.25	0	0	13.6	0.1	1.2
2025	10	18	10	12	15	0	0	0	0	0	0	0	10.28	0	0	13.8	0.1	1.2
2025	10	18	10	22	15	0	0	0	0	0	0	0	10.3	0	0	13.8	0.1	1.2
2025	10	18	10	32	15	0	0	0	0	0	0	0	10.33	0	0	13.6	0.1	1.2
2025	10	18	10	42	15	0	0	0	0	0	0	0	10.35	0	0	13.6	0.1	1.2
2025	10	18	10	52	15	0	0	0	0	0	0	0	10.37	0	0	13.6	0.1	1.2
2025	10	18	11	2	15	0	0	0	0	0	0	0	10.4	0	0	13.6	0.1	1.2
2025	10	18	11	12	15	0	0	0	0	0	0	0	10.42	0	0	14.2	0.1	1.2
2025	10	18	11	22	15	0	0	0	0	0	0	0	10.44	0	0	14.2	0.1	1.2
2025	10	18	11	32	15	0	0	0	0	0	0	0	10.47	0	0	13.6	0.1	1.2
2025	10	18	11	42	15	0	0	0	0	0	0	0	10.49	0	0	14.2	0.1	1.2
2025	10	18	11	52	15	0	0	0	0	0	0	0	10.51	0	0	14.2	0.1	1.2
2025	10	18	12	2	15	0	0	0	0	0	0	0	10.52	0	0	14.2	0.1	1.2
2025	10	18	12	12	15	0	0	0	0	0	0	0	10.55	0	0	14.2	0.1	1.2
2025	10	18	12	22	15	0	0	0	0	0	0	0	10.57	0	0	14.2	0.1	1.2
2025	10	18	12	32	15	0	0	0	0	0	0	0	10.59	0	0	13.6	0.1	1.2
2025	10	18	12	42	15	0	0	0	0	0	0	0	10.6	0	0	13.6	0.1	1.2
2025	10	18	12	52	15	0	0	0	0	0	0	0	10.62	0	0	13.6	0.1	1.2
2025	10	18	13	2	15	0	0	0	0	0	0	0	10.63	0	0	13.6	0.1	1.2
2025	10	18	13	12	15	0	0	0	0	0	0	0	10.64	0	0	13.6	0.1	1.2
2025	10	18	13	22	15	0	0	0	0	0	0	0	10.65	0	0	13.6	0.1	1.2
2025	10	18	13	32	15	0	0	0	0	0	0	0	10.65	0	0	13.6	0.1	1.2
2025	10	18	13	42	15	0	0	0	0	0	0	0	10.67	0	0	13.6	0.1	1.2
2025	10	18	13	52	15	0	0	0	0	0	0	0	10.66	0	0	13.6	0.1	1.2
2025	10	18	14	2	15	0	0	0	0	0	0	0	10.65	0	0	13.6	0.1	1.2
2025	10	18	14	12	15	0	0	0	0	0	0	0	10.65	0	0	13.6	0.1	1.2
2025	10	18	14	22	15	0	0	0	0	0	0	0	10.65	0	0	13.6	0.1	1.2
2025	10	18	14	32	15	0	0	0	0	0	0	0	10.65	0	0	13.6	0.1	1.2
2025	10	18	14	42	15	0	0	0	0	0	0	0	10.65	0	0	13.6	0.1	1.2
2025	10	18	14	52	15	0	0	0	0	0	0	0	10.64	0	0	13.6	0.1	1.2
2025	10	18	15	2	15	0	0	0	0	0	0	0	10.63	0	0	13.6	0.1	1.2
2025	10	18	15	12	15	0	0	0	0	0	0	0	10.64	0	0	13.6	0.1	1.2
2025	10	18	15	22	15	0	0	0	0	0	0	0	10.64	0	0	13.6	0.1	1.2
2025	10	18	15	32	15	0	0	0	0	0	0	0	10.63	0	0	13.6	0.1	1.2
2025	10	18	15	42	15	0	0	0	0	0	0	0	10.62	0	0	13.6	0.1	1.2
2025	10	18	15	52	15	0	0	0	0	0	0	0	10.6	0	0	13.6	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	18	16	2	15	0	0	0	0	0	0	0	10.57	0	0	13.6	0.1	1.2
2025	10	18	16	12	15	0	0	0	0	0	0	0	10.58	0	0	13.6	0.1	1.2
2025	10	18	16	22	15	0	0	0	0	0	0	0	10.54	0	0	13.6	0.1	1.2
2025	10	18	16	32	15	0	0	0	0	0	0	0	10.53	0	0	13	0.1	1.2
2025	10	18	16	42	15	0	0	0	0	0	0	0	10.53	0	0	12.6	0.1	1.2
2025	10	18	16	52	15	0	0	0	0	0	0	0	10.5	0	0	12.4	0.1	1.2
2025	10	18	17	2	15	0	0	0	0	0	0	0	10.5	0	0	12.2	0.1	1.2
2025	10	18	17	12	15	0	0	0	0	0	0	0	10.49	0	0	12	0.1	1.2
2025	10	18	17	22	15	0	0	0	0	0	0	0	10.49	0	0	12	0.1	1.2
2025	10	18	17	32	15	0	0	0	0	0	0	0	10.48	0	0	11.8	0.1	1.2
2025	10	18	17	42	15	0	0	0	0	0	0	0	10.47	0	0	11.8	0.1	1.2
2025	10	18	17	52	15	0	0	0	0	0	0	0	10.46	0	0	11.8	0.1	1.2
2025	10	18	18	2	15	0	0	0	0	0	0	0	10.45	0	0	11.8	0.1	1.2
2025	10	18	18	12	15	0	0	0	0	0	0	0	10.44	0	0	11.8	0.1	1.2
2025	10	18	18	22	15	0	0	0	0	0	0	0	10.42	0	0	11.8	0.1	1.2
2025	10	18	18	32	15	0	0	0	0	0	0	0	10.41	0	0	11.8	0.1	1.2
2025	10	18	18	42	15	0	0	0	0	0	0	0	10.39	0	0	11.8	0.1	1.2
2025	10	18	18	52	15	0	0	0	0	0	0	0	10.38	0	0	11.8	0.1	1.2
2025	10	18	19	2	15	0	0	0	0	0	0	0	10.36	0	0	11.8	0.1	1.2
2025	10	18	19	12	15	0	0	0	0	0	0	0	10.34	0	0	11.8	0.1	1.2
2025	10	18	19	22	15	0	0	0	0	0	0	0	10.33	0	0	11.8	0.1	1.2
2025	10	18	19	32	15	0	0	0	0	0	0	0	10.31	0	0	11.8	0.1	1.2
2025	10	18	19	42	15	0	0	0	0	0	0	0	10.29	0	0	11.8	0.1	1.2
2025	10	18	19	52	15	0	0	0	0	0	0	0	10.27	0	0	11.6	0.1	1.2
2025	10	18	20	2	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1.2
2025	10	18	20	12	15	0	0	0	0	0	0	0	10.24	0	0	11.6	0.1	1.2
2025	10	18	20	22	15	0	0	0	0	0	0	0	10.23	0	0	11.6	0.1	1.2
2025	10	18	20	32	15	0	0	0	0	0	0	0	10.21	0	0	11.6	0.1	1.2
2025	10	18	20	42	15	0	0	0	0	0	0	0	10.19	0	0	11.6	0.1	1.2
2025	10	18	20	52	15	0	0	0	0	0	0	0	10.18	0	0	11.6	0.1	1.2
2025	10	18	21	2	15	0	0	0	0	0	0	0	10.17	0	0	11.6	0.1	1.2
2025	10	18	21	12	15	0	0	0	0	0	0	0	10.16	0	0	11.6	0.1	1.2
2025	10	18	21	22	15	0	0	0	0	0	0	0	10.15	0	0	11.6	0.1	1.2
2025	10	18	21	32	15	0	0	0	0	0	0	0	10.13	0	0	11.6	0.1	1.2
2025	10	18	21	42	15	0	0	0	0	0	0	0	10.12	0	0	11.6	0.1	1.2
2025	10	18	21	52	15	0	0	0	0	0	0	0	10.11	0	0	11.6	0.1	1.2
2025	10	18	22	2	15	0	0	0	0	0	0	0	10.1	0	0	11.6	0.1	1.2
2025	10	18	22	12	15	0	0	0	0	0	0	0	10.08	0	0	11.6	0.1	1.2
2025	10	18	22	22	15	0	0	0	0	0	0	0	10.08	0	0	11.6	0.1	1.2
2025	10	18	22	32	15	0	0	0	0	0	0	0	10.07	0	0	11.6	0.1	1.2
2025	10	18	22	42	15	0	0	0	0	0	0	0	10.06	0	0	11.6	0.1	1.2
2025	10	18	22	52	15	0	0	0	0	0	0	0	10.05	0	0	11.6	0.1	1.2
2025	10	18	23	2	15	0	0	0	0	0	0	0	10.05	0	0	11.6	0.1	1.2
2025	10	18	23	12	15	0	0	0	0	0	0	0	10.05	0	0	11.6	0.1	1.2
2025	10	18	23	22	15	0	0	0	0	0	0	0	10.04	0	0	11.6	0.1	1.2
2025	10	18	23	32	15	0	0	0	0	0	0	0	10.04	0	0	11.6	0.1	1.2
2025	10	18	23	42	15	0	0	0	0	0	0	0	10.03	0	0	11.6	0.1	1.2
2025	10	18	23	52	15	0	0	0	0	0	0	0	10.03	0	0	11.6	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	19	0	2	15	0	0	0	0	0	0	0	10.03	0	0	11.6	0.1	1.2
2025	10	19	0	12	15	0	0	0	0	0	0	0	10.02	0	0	11.6	0.1	1.2
2025	10	19	0	22	15	0	0	0	0	0	0	0	10.02	0	0	11.6	0.1	1.2
2025	10	19	0	32	15	0	0	0	0	0	0	0	10.02	0	0	11.6	0.1	1.2
2025	10	19	0	42	15	0	0	0	0	0	0	0	10.02	0	0	11.6	0.1	1.2
2025	10	19	0	52	15	0	0	0	0	0	0	0	10.02	0	0	11.6	0.1	1.2
2025	10	19	1	2	15	0	0	0	0	0	0	0	10.03	0	0	11.6	0.1	1.2
2025	10	19	1	12	15	0	0	0	0	0	0	0	10.03	0	0	11.6	0.1	1.2
2025	10	19	1	22	15	0	0	0	0	0	0	0	10.03	0	0	11.6	0.1	1.2
2025	10	19	1	32	15	0	0	0	0	0	0	0	10.04	0	0	11.6	0.1	1.2
2025	10	19	1	42	15	0	0	0	0	0	0	0	10.04	0	0	11.6	0.1	1.2
2025	10	19	1	52	15	0	0	0	0	0	0	0	10.05	0	0	11.6	0.1	1.2
2025	10	19	2	2	15	0	0	0	0	0	0	0	10.05	0	0	11.6	0.1	1.2
2025	10	19	2	12	15	0	0	0	0	0	0	0	10.06	0	0	11.6	0.1	1.2
2025	10	19	2	22	15	0	0	0	0	0	0	0	10.06	0	0	11.6	0.1	1.2
2025	10	19	2	32	15	0	0	0	0	0	0	0	10.07	0	0	11.6	0.1	1.2
2025	10	19	2	42	15	0	0	0	0	0	0	0	10.08	0	0	11.6	0.1	1.2
2025	10	19	2	52	15	0	0	0	0	0	0	0	10.09	0	0	11.6	0.1	1.2
2025	10	19	3	2	15	0	0	0	0	0	0	0	10.09	0	0	11.6	0.1	1.2
2025	10	19	3	12	15	0	0	0	0	0	0	0	10.1	0	0	11.6	0.1	1.2
2025	10	19	3	22	15	0	0	0	0	0	0	0	10.11	0	0	11.6	0.1	1.2
2025	10	19	3	32	15	0	0	0	0	0	0	0	10.12	0	0	11.6	0.1	1.2
2025	10	19	3	42	15	0	0	0	0	0	0	0	10.12	0	0	11.4	0.1	1.2
2025	10	19	3	52	15	0	0	0	0	0	0	0	10.13	0	0	11.4	0.1	1.2
2025	10	19	4	2	15	0	0	0	0	0	0	0	10.14	0	0	11.4	0.1	1.2
2025	10	19	4	12	15	0	0	0	0	0	0	0	10.14	0	0	11.4	0.1	1.2
2025	10	19	4	22	15	0	0	0	0	0	0	0	10.14	0	0	11.4	0.1	1.2
2025	10	19	4	32	15	0	0	0	0	0	0	0	10.15	0	0	11.4	0.1	1.2
2025	10	19	4	42	15	0	0	0	0	0	0	0	10.15	0	0	11.4	0.1	1.2
2025	10	19	4	52	15	0	0	0	0	0	0	0	10.15	0	0	11.4	0.1	1.2
2025	10	19	5	2	15	0	0	0	0	0	0	0	10.16	0	0	11.4	0.1	1.2
2025	10	19	5	12	15	0	0	0	0	0	0	0	10.16	0	0	11.4	0.1	1.2
2025	10	19	5	22	15	0	0	0	0	0	0	0	10.17	0	0	11.4	0.1	1.2
2025	10	19	5	32	15	0	0	0	0	0	0	0	10.18	0	0	11.4	0.1	1.2
2025	10	19	5	42	15	0	0	0	0	0	0	0	10.17	0	0	11.4	0.1	1.2
2025	10	19	5	52	15	0	0	0	0	0	0	0	10.18	0	0	11.4	0.1	1.2
2025	10	19	6	2	15	0	0	0	0	0	0	0	10.18	0	0	11.4	0.1	1.2
2025	10	19	6	12	15	0	0	0	0	0	0	0	10.19	0	0	11.4	0.1	1.2
2025	10	19	6	22	15	0	0	0	0	0	0	0	10.18	0	0	11.4	0.1	1.2
2025	10	19	6	32	15	0	0	0	0	0	0	0	10.19	0	0	11.4	0.1	1.2
2025	10	19	6	42	15	0	0	0	0	0	0	0	10.19	0	0	11.4	0.1	1.2
2025	10	19	6	52	15	0	0	0	0	0	0	0	10.18	0	0	11.4	0.1	1.2
2025	10	19	7	2	15	0	0	0	0	0	0	0	10.18	0	0	11.4	0.1	1.2
2025	10	19	7	12	15	0	0	0	0	0	0	0	10.18	0	0	11.4	0.1	1.2
2025	10	19	7	22	15	0	0	0	0	0	0	0	10.18	0	0	11.4	0.1	1.2
2025	10	19	7	32	15	0	0	0	0	0	0	0	10.17	0	0	11.4	0.1	1.2
2025	10	19	7	42	15	0	0	0	0	0	0	0	10.17	0	0	11.4	0.1	1.2
2025	10	19	7	52	15	0	0	0	0	0	0	0	10.17	0	0	11.8	0.1	1.2

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	19	8	2	15	0	0	0	0	0	0	0	10.16	0	0	12	0.1	1.2
2025	10	19	8	12	15	0	0	0	0	0	0	0	10.17	0	0	12.2	0.1	1.2
2025	10	19	8	22	15	0	0	0	0	0	0	0	10.17	0	0	12.4	0.1	1.2
2025	10	19	8	32	15	0	0	0	0	0	0	0	10.18	0	0	12.4	0.1	1.2
2025	10	19	8	42	15	0	0	0	0	0	0	0	10.19	0	0	12.6	0.1	1.2
2025	10	19	8	52	15	0	0	0	0	0	0	0	10.27	0	0	12.6	0.1	1.2
2025	10	19	9	2	15	0	0	0	0	0	0	0	10.3	0	0	12.6	0.1	1.2
2025	10	19	9	12	15	0	0	0	0	0	0	0	10.33	0	0	12.8	0.1	1.2
2025	10	19	9	22	15	0	0	0	0	0	0	0	10.35	0	0	12.8	0.1	1.2
2025	10	19	9	32	15	0	0	0	0	0	0	0	10.39	0	0	13	0.1	1.2
2025	10	19	9	42	15	0	0	0	0	0	0	0	10.41	0	0	13	0.1	1.2
2025	10	19	9	52	15	0	0	0	0	0	0	0	10.44	0	0	13.4	0.1	1.2
2025	10	19	10	2	15	0	0	0	0	0	0	0	10.48	0	0	13.8	0.1	1.2
2025	10	19	10	12	15	0	0	0	0	0	0	0	10.51	0	0	13.8	0.1	1.2
2025	10	19	10	22	15	0	0	0	0	0	0	0	10.53	0	0	13.4	0.1	1.2
2025	10	19	10	32	15	0	0	0	0	0	0	0	10.57	0	0	13.4	0.1	1.2
2025	10	19	10	42	15	0	0	0	0	0	0	0	10.58	0	0	13.4	0.1	1.2
2025	10	19	10	52	15	0	0	0	0	0	0	0	10.62	0	0	13.4	0.1	1.2
2025	10	19	11	2	15	0	0	0	0	0	0	0	10.64	0	0	13.4	0.1	1.2
2025	10	19	11	12	15	0	0	0	0	0	0	0	10.66	0	0	13.6	0.1	1.2
2025	10	19	11	22	15	0	0	0	0	0	0	0	10.71	0	0	13.6	0.1	1.2
2025	10	19	11	32	15	0	0	0	0	0	0	0	10.73	0	0	13.6	0.1	1.2
2025	10	19	11	42	15	0	0	0	0	0	0	0	10.76	0	0	13.6	0.1	1.2
2025	10	19	11	52	15	0	0	0	0	0	0	0	10.78	0	0	13.6	0.1	1.1
2025	10	19	12	2	15	0	0	0	0	0	0	0	10.8	0	0	13.4	0.1	1.1
2025	10	19	12	12	15	0	0	0	0	0	0	0	10.82	0	0	13.6	0.1	1.1
2025	10	19	12	22	15	0	0	0	0	0	0	0	10.84	0	0	13.6	0.1	1.1
2025	10	19	12	32	15	0	0	0	0	0	0	0	10.87	0	0	13.6	0.1	1.1
2025	10	19	12	42	15	0	0	0	0	0	0	0	10.88	0	0	13.6	0.1	1.1
2025	10	19	12	52	15	0	0	0	0	0	0	0	10.9	0	0	13.6	0.1	1.1
2025	10	19	13	2	15	0	0	0	0	0	0	0	10.91	0	0	13.6	0.1	1.1
2025	10	19	13	12	15	0	0	0	0	0	0	0	10.93	0	0	13.6	0.1	1.1
2025	10	19	13	22	15	0	0	0	0	0	0	0	10.93	0	0	13.6	0.1	1.1
2025	10	19	13	32	15	0	0	0	0	0	0	0	10.94	0	0	13.6	0.1	1.1
2025	10	19	13	42	15	0	0	0	0	0	0	0	10.94	0	0	13.6	0.1	1.1
2025	10	19	13	52	15	0	0	0	0	0	0	0	10.93	0	0	13.6	0.1	1.1
2025	10	19	14	2	15	0	0	0	0	0	0	0	10.9	0	0	13.6	0.1	1.1
2025	10	19	14	12	15	0	0	0	0	0	0	0	10.9	0	0	13.6	0.1	1.1
2025	10	19	14	22	15	0	0	0	0	0	0	0	10.94	0	0	13.6	0.1	1.1
2025	10	19	14	32	15	0	0	0	0	0	0	0	10.94	0	0	13.6	0.1	1.1
2025	10	19	14	42	15	0	0	0	0	0	0	0	10.94	0	0	13.4	0.1	1.1
2025	10	19	14	52	15	0	0	0	0	0	0	0	10.92	0	0	13.4	0.1	1.1
2025	10	19	15	2	15	0	0	0	0	0	0	0	10.88	0	0	13.4	0.1	1.1
2025	10	19	15	12	15	0	0	0	0	0	0	0	10.89	0	0	13.4	0.1	1.1
2025	10	19	15	22	15	0	0	0	0	0	0	0	10.86	0	0	12.8	0.1	1.1
2025	10	19	15	32	15	0	0	0	0	0	0	0	10.82	0	0	13.4	0.1	1.1
2025	10	19	15	42	15	0	0	0	0	0	0	0	10.89	0	0	13.4	0.1	1.1
2025	10	19	15	52	15	0	0	0	0	0	0	0	10.88	0	0	13.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	19	16	2	15	0	0	0	0	0	0	0	10.86	0	0	13.4	0.1	1.1
2025	10	19	16	12	15	0	0	0	0	0	0	0	10.85	0	0	13	0.1	1.1
2025	10	19	16	22	15	0	0	0	0	0	0	0	10.8	0	0	12.8	0.1	1.1
2025	10	19	16	32	15	0	0	0	0	0	0	0	10.79	0	0	12.2	0.1	1.1
2025	10	19	16	42	15	0	0	0	0	0	0	0	10.79	0	0	12	0.1	1.1
2025	10	19	16	52	15	0	0	0	0	0	0	0	10.78	0	0	12	0.1	1.1
2025	10	19	17	2	15	0	0	0	0	0	0	0	10.78	0	0	12	0.1	1.1
2025	10	19	17	12	15	0	0	0	0	0	0	0	10.77	0	0	11.8	0.1	1.1
2025	10	19	17	22	15	0	0	0	0	0	0	0	10.76	0	0	11.8	0.1	1.1
2025	10	19	17	32	15	0	0	0	0	0	0	0	10.75	0	0	11.8	0.1	1.1
2025	10	19	17	42	15	0	0	0	0	0	0	0	10.74	0	0	11.8	0.1	1.1
2025	10	19	17	52	15	0	0	0	0	0	0	0	10.73	0	0	11.6	0.1	1.1
2025	10	19	18	2	15	0	0	0	0	0	0	0	10.71	0	0	11.6	0.1	1.1
2025	10	19	18	12	15	0	0	0	0	0	0	0	10.7	0	0	11.6	0.1	1.1
2025	10	19	18	22	15	0	0	0	0	0	0	0	10.68	0	0	11.6	0.1	1.1
2025	10	19	18	32	15	0	0	0	0	0	0	0	10.67	0	0	11.6	0.1	1.1
2025	10	19	18	42	15	0	0	0	0	0	0	0	10.66	0	0	11.6	0.1	1.1
2025	10	19	18	52	15	0	0	0	0	0	0	0	10.64	0	0	11.6	0.1	1.1
2025	10	19	19	2	15	0	0	0	0	0	0	0	10.62	0	0	11.6	0.1	1.1
2025	10	19	19	12	15	0	0	0	0	0	0	0	10.61	0	0	11.6	0.1	1.1
2025	10	19	19	22	15	0	0	0	0	0	0	0	10.59	0	0	11.6	0.1	1.1
2025	10	19	19	32	15	0	0	0	0	0	0	0	10.57	0	0	11.6	0.1	1.1
2025	10	19	19	42	15	0	0	0	0	0	0	0	10.55	0	0	11.6	0.1	1.1
2025	10	19	19	52	15	0	0	0	0	0	0	0	10.54	0	0	11.6	0.1	1.1
2025	10	19	20	2	15	0	0	0	0	0	0	0	10.52	0	0	11.6	0.1	1.1
2025	10	19	20	12	15	0	0	0	0	0	0	0	10.5	0	0	11.6	0.1	1.1
2025	10	19	20	22	15	0	0	0	0	0	0	0	10.48	0	0	11.6	0.1	1.1
2025	10	19	20	32	15	0	0	0	0	0	0	0	10.47	0	0	11.6	0.1	1.1
2025	10	19	20	42	15	0	0	0	0	0	0	0	10.45	0	0	11.6	0.1	1.1
2025	10	19	20	52	15	0	0	0	0	0	0	0	10.44	0	0	11.6	0.1	1.1
2025	10	19	21	2	15	0	0	0	0	0	0	0	10.42	0	0	11.6	0.1	1.1
2025	10	19	21	12	15	0	0	0	0	0	0	0	10.41	0	0	11.6	0.1	1.1
2025	10	19	21	22	15	0	0	0	0	0	0	0	10.39	0	0	11.6	0.1	1.1
2025	10	19	21	32	15	0	0	0	0	0	0	0	10.38	0	0	11.6	0.1	1.1
2025	10	19	21	42	15	0	0	0	0	0	0	0	10.37	0	0	11.6	0.1	1.1
2025	10	19	21	52	15	0	0	0	0	0	0	0	10.36	0	0	11.6	0.1	1.1
2025	10	19	22	2	15	0	0	0	0	0	0	0	10.35	0	0	11.6	0.1	1.1
2025	10	19	22	12	15	0	0	0	0	0	0	0	10.34	0	0	11.6	0.1	1.1
2025	10	19	22	22	15	0	0	0	0	0	0	0	10.33	0	0	11.6	0.1	1.1
2025	10	19	22	32	15	0	0	0	0	0	0	0	10.33	0	0	11.6	0.1	1.1
2025	10	19	22	42	15	0	0	0	0	0	0	0	10.32	0	0	11.6	0.1	1.1
2025	10	19	22	52	15	0	0	0	0	0	0	0	10.31	0	0	11.4	0.1	1.1
2025	10	19	23	2	15	0	0	0	0	0	0	0	10.3	0	0	11.4	0.1	1.1
2025	10	19	23	12	15	0	0	0	0	0	0	0	10.3	0	0	11.4	0.1	1.1
2025	10	19	23	22	15	0	0	0	0	0	0	0	10.29	0	0	11.4	0.1	1.1
2025	10	19	23	32	15	0	0	0	0	0	0	0	10.28	0	0	11.4	0.1	1.1
2025	10	19	23	42	15	0	0	0	0	0	0	0	10.28	0	0	11.4	0.1	1.1
2025	10	19	23	52	15	0	0	0	0	0	0	0	10.28	0	0	11.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	20	0	2	15	0	0	0	0	0	0	0	10.27	0	0	11.4	0.1	1.1
2025	10	20	0	12	15	0	0	0	0	0	0	0	10.27	0	0	11.4	0.1	1.1
2025	10	20	0	22	15	0	0	0	0	0	0	0	10.27	0	0	11.4	0.1	1.1
2025	10	20	0	32	15	0	0	0	0	0	0	0	10.28	0	0	11.4	0.1	1.1
2025	10	20	0	42	15	0	0	0	0	0	0	0	10.28	0	0	11.4	0.1	1.1
2025	10	20	0	52	15	0	0	0	0	0	0	0	10.27	0	0	11.4	0.1	1.1
2025	10	20	1	2	15	0	0	0	0	0	0	0	10.28	0	0	11.4	0.1	1.1
2025	10	20	1	12	15	0	0	0	0	0	0	0	10.29	0	0	11.4	0.1	1.1
2025	10	20	1	22	15	0	0	0	0	0	0	0	10.29	0	0	11.4	0.1	1.1
2025	10	20	1	32	15	0	0	0	0	0	0	0	10.29	0	0	11.4	0.1	1.1
2025	10	20	1	42	15	0	0	0	0	0	0	0	10.3	0	0	11.4	0.1	1.1
2025	10	20	1	52	15	0	0	0	0	0	0	0	10.31	0	0	11.4	0.1	1.1
2025	10	20	2	2	15	0	0	0	0	0	0	0	10.31	0	0	11.4	0.1	1.1
2025	10	20	2	12	15	0	0	0	0	0	0	0	10.32	0	0	11.4	0.1	1.1
2025	10	20	2	22	15	0	0	0	0	0	0	0	10.33	0	0	11.4	0.1	1.1
2025	10	20	2	32	15	0	0	0	0	0	0	0	10.33	0	0	11.4	0.1	1.1
2025	10	20	2	42	15	0	0	0	0	0	0	0	10.33	0	0	11.4	0.1	1.1
2025	10	20	2	52	15	0	0	0	0	0	0	0	10.34	0	0	11.4	0.1	1.1
2025	10	20	3	2	15	0	0	0	0	0	0	0	10.35	0	0	11.4	0.1	1.1
2025	10	20	3	12	15	0	0	0	0	0	0	0	10.36	0	0	11.4	0.1	1.1
2025	10	20	3	22	15	0	0	0	0	0	0	0	10.36	0	0	11.4	0.1	1.1
2025	10	20	3	32	15	0	0	0	0	0	0	0	10.37	0	0	11.4	0.1	1.1
2025	10	20	3	42	15	0	0	0	0	0	0	0	10.37	0	0	11.4	0.1	1.1
2025	10	20	3	52	15	0	0	0	0	0	0	0	10.38	0	0	11.4	0.1	1.1
2025	10	20	4	2	15	0	0	0	0	0	0	0	10.39	0	0	11.4	0.1	1.1
2025	10	20	4	12	15	0	0	0	0	0	0	0	10.39	0	0	11.4	0.1	1.1
2025	10	20	4	22	15	0	0	0	0	0	0	0	10.4	0	0	11.4	0.1	1.1
2025	10	20	4	32	15	0	0	0	0	0	0	0	10.41	0	0	11.4	0.1	1.1
2025	10	20	4	42	15	0	0	0	0	0	0	0	10.41	0	0	11.4	0.1	1.1
2025	10	20	4	52	15	0	0	0	0	0	0	0	10.42	0	0	11.4	0.1	1.1
2025	10	20	5	2	15	0	0	0	0	0	0	0	10.42	0	0	11.4	0.1	1.1
2025	10	20	5	12	15	0	0	0	0	0	0	0	10.43	0	0	11.4	0.1	1.1
2025	10	20	5	22	15	0	0	0	0	0	0	0	10.44	0	0	11.4	0.1	1.1
2025	10	20	5	32	15	0	0	0	0	0	0	0	10.44	0	0	11.4	0.1	1.1
2025	10	20	5	42	15	0	0	0	0	0	0	0	10.44	0	0	11.4	0.1	1.1
2025	10	20	5	52	15	0	0	0	0	0	0	0	10.45	0	0	11.4	0.1	1.1
2025	10	20	6	2	15	0	0	0	0	0	0	0	10.45	0	0	11.4	0.1	1.1
2025	10	20	6	12	15	0	0	0	0	0	0	0	10.45	0	0	11.4	0.1	1.1
2025	10	20	6	22	15	0	0	0	0	0	0	0	10.45	0	0	11.4	0.1	1.1
2025	10	20	6	32	15	0	0	0	0	0	0	0	10.45	0	0	11.4	0.1	1.1
2025	10	20	6	42	15	0	0	0	0	0	0	0	10.45	0	0	11.4	0.1	1.1
2025	10	20	6	52	15	0	0	0	0	0	0	0	10.45	0	0	11.4	0.1	1.1
2025	10	20	7	2	15	0	0	0	0	0	0	0	10.44	0	0	11.4	0.1	1.1
2025	10	20	7	12	15	0	0	0	0	0	0	0	10.44	0	0	11.4	0.1	1.1
2025	10	20	7	22	15	0	0	0	0	0	0	0	10.44	0	0	11.4	0.1	1.1
2025	10	20	7	32	15	0	0	0	0	0	0	0	10.44	0	0	11.4	0.1	1.1
2025	10	20	7	42	15	0	0	0	0	0	0	0	10.43	0	0	11.4	0.1	1.1
2025	10	20	7	52	15	0	0	0	0	0	0	0	10.43	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	20	8	2	15	0	0	0	0	0	0	0	10.43	0	0	11.8	0.1	1.1
2025	10	20	8	12	15	0	0	0	0	0	0	0	10.42	0	0	12	0.1	1.1
2025	10	20	8	22	15	0	0	0	0	0	0	0	10.43	0	0	12.2	0.1	1.1
2025	10	20	8	32	15	0	0	0	0	0	0	0	10.43	0	0	12.4	0.1	1.1
2025	10	20	8	42	15	0	0	0	0	0	0	0	10.45	0	0	12.4	0.1	1.1
2025	10	20	8	52	15	0	0	0	0	0	0	0	10.5	0	0	12.6	0.1	1.1
2025	10	20	9	2	15	0	0	0	0	0	0	0	10.53	0	0	12.6	0.1	1.1
2025	10	20	9	12	15	0	0	0	0	0	0	0	10.56	0	0	12.8	0.1	1.1
2025	10	20	9	22	15	0	0	0	0	0	0	0	10.58	0	0	13	0.1	1.1
2025	10	20	9	32	15	0	0	0	0	0	0	0	10.61	0	0	13.2	0.1	1.1
2025	10	20	9	42	15	0	0	0	0	0	0	0	10.64	0	0	13.4	0.1	1.1
2025	10	20	9	52	15	0	0	0	0	0	0	0	10.67	0	0	13.6	0.1	1.1
2025	10	20	10	2	15	0	0	0	0	0	0	0	10.69	0	0	13.6	0.1	1.1
2025	10	20	10	12	15	0	0	0	0	0	0	0	10.72	0	0	13.8	0.1	1.1
2025	10	20	10	22	15	0	0	0	0	0	0	0	10.75	0	0	14.2	0.1	1.1
2025	10	20	10	32	15	0	0	0	0	0	0	0	10.77	0	0	13.8	0.1	1.1
2025	10	20	10	42	15	0	0	0	0	0	0	0	10.8	0	0	13.8	0.1	1.1
2025	10	20	10	52	15	0	0	0	0	0	0	0	10.82	0	0	13.8	0.1	1.1
2025	10	20	11	2	15	0	0	0	0	0	0	0	10.84	0	0	13.6	0.1	1.1
2025	10	20	11	12	15	0	0	0	0	0	0	0	10.86	0	0	13.6	0.1	1.1
2025	10	20	11	22	15	0	0	0	0	0	0	0	10.88	0	0	13.6	0.1	1.1
2025	10	20	11	32	15	0	0	0	0	0	0	0	10.91	0	0	13.6	0.1	1.1
2025	10	20	11	42	15	0	0	0	0	0	0	0	10.93	0	0	13.6	0.1	1.1
2025	10	20	11	52	15	0	0	0	0	0	0	0	10.95	0	0	13.6	0.1	1.1
2025	10	20	12	2	15	0	0	0	0	0	0	0	10.97	0	0	13.6	0.1	1.1
2025	10	20	12	12	15	0	0	0	0	0	0	0	11	0	0	13.6	0.1	1.1
2025	10	20	12	22	15	0	0	0	0	0	0	0	11.01	0	0	13.6	0.1	1.1
2025	10	20	12	32	15	0	0	0	0	0	0	0	11.04	0	0	13.4	0.1	1.1
2025	10	20	12	42	15	0	0	0	0	0	0	0	11.09	0	0	13.4	0.1	1.1
2025	10	20	12	52	15	0	0	0	0	0	0	0	11.1	0	0	13.4	0.1	1.1
2025	10	20	13	2	15	0	0	0	0	0	0	0	11.13	0	0	13.4	0.1	1.1
2025	10	20	13	12	15	0	0	0	0	0	0	0	11.14	0	0	13.4	0.1	1.1
2025	10	20	13	22	15	0	0	0	0	0	0	0	11.15	0	0	13.4	0.1	1.1
2025	10	20	13	32	15	0	0	0	0	0	0	0	11.15	0	0	13.4	0.1	1.1
2025	10	20	13	42	15	0	0	0	0	0	0	0	11.16	0	0	13.4	0.1	1.1
2025	10	20	13	52	15	0	0	0	0	0	0	0	11.17	0	0	13.4	0.1	1.1
2025	10	20	14	2	15	0	0	0	0	0	0	0	11.17	0	0	13.4	0.1	1.1
2025	10	20	14	12	15	0	0	0	0	0	0	0	11.17	0	0	13.2	0.1	1.1
2025	10	20	14	22	15	0	0	0	0	0	0	0	11.16	0	0	13.4	0.1	1.1
2025	10	20	14	32	15	0	0	0	0	0	0	0	11.16	0	0	13	0.1	1.1
2025	10	20	14	42	15	0	0	0	0	0	0	0	11.16	0	0	13	0.1	1.1
2025	10	20	14	52	15	0	0	0	0	0	0	0	11.14	0	0	13	0.1	1.1
2025	10	20	15	2	15	0	0	0	0	0	0	0	11.14	0	0	13	0.1	1.1
2025	10	20	15	12	15	0	0	0	0	0	0	0	11.13	0	0	13	0.1	1.1
2025	10	20	15	22	15	0	0	0	0	0	0	0	11.13	0	0	13	0.1	1.1
2025	10	20	15	32	15	0	0	0	0	0	0	0	11.12	0	0	13	0.1	1.1
2025	10	20	15	42	15	0	0	0	0	0	0	0	11.11	0	0	13	0.1	1.1
2025	10	20	15	52	15	0	0	0	0	0	0	0	11.09	0	0	13	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	20	16	2	15	0	0	0	0	0	0	0	11.06	0	0	13.2	0.1	1.1
2025	10	20	16	12	15	0	0	0	0	0	0	0	11.05	0	0	13.2	0.1	1.1
2025	10	20	16	22	15	0	0	0	0	0	0	0	11	0	0	13.2	0.1	1.1
2025	10	20	16	32	15	0	0	0	0	0	0	0	10.98	0	0	12.6	0.1	1.1
2025	10	20	16	42	15	0	0	0	0	0	0	0	10.98	0	0	12.4	0.1	1.1
2025	10	20	16	52	15	0	0	0	0	0	0	0	10.97	0	0	12.2	0.1	1.1
2025	10	20	17	2	15	0	0	0	0	0	0	0	10.96	0	0	12	0.1	1.1
2025	10	20	17	12	15	0	0	0	0	0	0	0	10.96	0	0	12	0.1	1.1
2025	10	20	17	22	15	0	0	0	0	0	0	0	10.95	0	0	11.8	0.1	1.1
2025	10	20	17	32	15	0	0	0	0	0	0	0	10.94	0	0	11.8	0.1	1.1
2025	10	20	17	42	15	0	0	0	0	0	0	0	10.93	0	0	11.8	0.1	1.1
2025	10	20	17	52	15	0	0	0	0	0	0	0	10.93	0	0	11.8	0.1	1.1
2025	10	20	18	2	15	0	0	0	0	0	0	0	10.91	0	0	11.6	0.1	1.1
2025	10	20	18	12	15	0	0	0	0	0	0	0	10.9	0	0	11.6	0.1	1.1
2025	10	20	18	22	15	0	0	0	0	0	0	0	10.88	0	0	11.6	0.1	1.1
2025	10	20	18	32	15	0	0	0	0	0	0	0	10.87	0	0	11.6	0.1	1.1
2025	10	20	18	42	15	0	0	0	0	0	0	0	10.85	0	0	11.6	0.1	1.1
2025	10	20	18	52	15	0	0	0	0	0	0	0	10.84	0	0	11.6	0.1	1.1
2025	10	20	19	2	15	0	0	0	0	0	0	0	10.82	0	0	11.6	0.1	1.1
2025	10	20	19	12	15	0	0	0	0	0	0	0	10.81	0	0	11.6	0.1	1.1
2025	10	20	19	22	15	0	0	0	0	0	0	0	10.79	0	0	11.6	0.1	1.1
2025	10	20	19	32	15	0	0	0	0	0	0	0	10.77	0	0	11.6	0.1	1.1
2025	10	20	19	42	15	0	0	0	0	0	0	0	10.75	0	0	11.6	0.1	1.1
2025	10	20	19	52	15	0	0	0	0	0	0	0	10.74	0	0	11.6	0.1	1.1
2025	10	20	20	2	15	0	0	0	0	0	0	0	10.72	0	0	11.6	0.1	1.1
2025	10	20	20	12	15	0	0	0	0	0	0	0	10.7	0	0	11.6	0.1	1.1
2025	10	20	20	22	15	0	0	0	0	0	0	0	10.68	0	0	11.6	0.1	1.1
2025	10	20	20	32	15	0	0	0	0	0	0	0	10.67	0	0	11.6	0.1	1.1
2025	10	20	20	42	15	0	0	0	0	0	0	0	10.66	0	0	11.6	0.1	1.1
2025	10	20	20	52	15	0	0	0	0	0	0	0	10.64	0	0	11.6	0.1	1.1
2025	10	20	21	2	15	0	0	0	0	0	0	0	10.62	0	0	11.6	0.1	1.1
2025	10	20	21	12	15	0	0	0	0	0	0	0	10.61	0	0	11.6	0.1	1.1
2025	10	20	21	22	15	0	0	0	0	0	0	0	10.59	0	0	11.6	0.1	1.1
2025	10	20	21	32	15	0	0	0	0	0	0	0	10.58	0	0	11.6	0.1	1.1
2025	10	20	21	42	15	0	0	0	0	0	0	0	10.57	0	0	11.6	0.1	1.1
2025	10	20	21	52	15	0	0	0	0	0	0	0	10.56	0	0	11.6	0.1	1.1
2025	10	20	22	2	15	0	0	0	0	0	0	0	10.55	0	0	11.6	0.1	1.1
2025	10	20	22	12	15	0	0	0	0	0	0	0	10.54	0	0	11.6	0.1	1.1
2025	10	20	22	22	15	0	0	0	0	0	0	0	10.53	0	0	11.6	0.1	1.1
2025	10	20	22	32	15	0	0	0	0	0	0	0	10.51	0	0	11.6	0.1	1.1
2025	10	20	22	42	15	0	0	0	0	0	0	0	10.51	0	0	11.6	0.1	1.1
2025	10	20	22	52	15	0	0	0	0	0	0	0	10.5	0	0	11.6	0.1	1.1
2025	10	20	23	2	15	0	0	0	0	0	0	0	10.5	0	0	11.6	0.1	1.1
2025	10	20	23	12	15	0	0	0	0	0	0	0	10.49	0	0	11.6	0.1	1.1
2025	10	20	23	22	15	0	0	0	0	0	0	0	10.48	0	0	11.6	0.1	1.1
2025	10	20	23	32	15	0	0	0	0	0	0	0	10.48	0	0	11.6	0.1	1.1
2025	10	20	23	42	15	0	0	0	0	0	0	0	10.47	0	0	11.6	0.1	1.1
2025	10	20	23	52	15	0	0	0	0	0	0	0	10.47	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	21	0	2	15	0	0	0	0	0	0	0	10.47	0	0	11.6	0.1	1.1
2025	10	21	0	12	15	0	0	0	0	0	0	0	10.46	0	0	11.6	0.1	1.1
2025	10	21	0	22	15	0	0	0	0	0	0	0	10.46	0	0	11.6	0.1	1.1
2025	10	21	0	32	15	0	0	0	0	0	0	0	10.46	0	0	11.6	0.1	1.1
2025	10	21	0	42	15	0	0	0	0	0	0	0	10.46	0	0	11.6	0.1	1.1
2025	10	21	0	52	15	0	0	0	0	0	0	0	10.47	0	0	11.6	0.1	1.1
2025	10	21	1	2	15	0	0	0	0	0	0	0	10.47	0	0	11.6	0.1	1.1
2025	10	21	1	12	15	0	0	0	0	0	0	0	10.48	0	0	11.6	0.1	1.1
2025	10	21	1	22	15	0	0	0	0	0	0	0	10.48	0	0	11.6	0.1	1.1
2025	10	21	1	32	15	0	0	0	0	0	0	0	10.48	0	0	11.6	0.1	1.1
2025	10	21	1	42	15	0	0	0	0	0	0	0	10.49	0	0	11.4	0.1	1.1
2025	10	21	1	52	15	0	0	0	0	0	0	0	10.5	0	0	11.4	0.1	1.1
2025	10	21	2	2	15	0	0	0	0	0	0	0	10.5	0	0	11.4	0.1	1.1
2025	10	21	2	12	15	0	0	0	0	0	0	0	10.51	0	0	11.4	0.1	1.1
2025	10	21	2	22	15	0	0	0	0	0	0	0	10.51	0	0	11.4	0.1	1.1
2025	10	21	2	32	15	0	0	0	0	0	0	0	10.52	0	0	11.4	0.1	1.1
2025	10	21	2	42	15	0	0	0	0	0	0	0	10.53	0	0	11.4	0.1	1.1
2025	10	21	2	52	15	0	0	0	0	0	0	0	10.54	0	0	11.4	0.1	1.1
2025	10	21	3	2	15	0	0	0	0	0	0	0	10.54	0	0	11.4	0.1	1.1
2025	10	21	3	12	15	0	0	0	0	0	0	0	10.55	0	0	11.4	0.1	1.1
2025	10	21	3	22	15	0	0	0	0	0	0	0	10.56	0	0	11.4	0.1	1.1
2025	10	21	3	32	15	0	0	0	0	0	0	0	10.57	0	0	11.4	0.1	1.1
2025	10	21	3	42	15	0	0	0	0	0	0	0	10.57	0	0	11.4	0.1	1.1
2025	10	21	3	52	15	0	0	0	0	0	0	0	10.58	0	0	11.4	0.1	1.1
2025	10	21	4	2	15	0	0	0	0	0	0	0	10.59	0	0	11.4	0.1	1.1
2025	10	21	4	12	15	0	0	0	0	0	0	0	10.59	0	0	11.4	0.1	1.1
2025	10	21	4	22	15	0	0	0	0	0	0	0	10.59	0	0	11.4	0.1	1.1
2025	10	21	4	32	15	0	0	0	0	0	0	0	10.6	0	0	11.4	0.1	1.1
2025	10	21	4	42	15	0	0	0	0	0	0	0	10.61	0	0	11.4	0.1	1.1
2025	10	21	4	52	15	0	0	0	0	0	0	0	10.61	0	0	11.4	0.1	1.1
2025	10	21	5	2	15	0	0	0	0	0	0	0	10.62	0	0	11.4	0.1	1.1
2025	10	21	5	12	15	0	0	0	0	0	0	0	10.62	0	0	11.4	0.1	1.1
2025	10	21	5	22	15	0	0	0	0	0	0	0	10.62	0	0	11.4	0.1	1.1
2025	10	21	5	32	15	0	0	0	0	0	0	0	10.62	0	0	11.4	0.1	1.1
2025	10	21	5	42	15	0	0	0	0	0	0	0	10.63	0	0	11.4	0.1	1.1
2025	10	21	5	52	15	0	0	0	0	0	0	0	10.63	0	0	11.4	0.1	1.1
2025	10	21	6	2	15	0	0	0	0	0	0	0	10.63	0	0	11.4	0.1	1.1
2025	10	21	6	12	15	0	0	0	0	0	0	0	10.64	0	0	11.4	0.1	1.1
2025	10	21	6	22	15	0	0	0	0	0	0	0	10.64	0	0	11.4	0.1	1.1
2025	10	21	6	32	15	0	0	0	0	0	0	0	10.64	0	0	11.4	0.1	1.1
2025	10	21	6	42	15	0	0	0	0	0	0	0	10.64	0	0	11.4	0.1	1.1
2025	10	21	6	52	15	0	0	0	0	0	0	0	10.64	0	0	11.4	0.1	1.1
2025	10	21	7	2	15	0	0	0	0	0	0	0	10.64	0	0	11.4	0.1	1.1
2025	10	21	7	12	15	0	0	0	0	0	0	0	10.64	0	0	11.4	0.1	1.1
2025	10	21	7	22	15	0	0	0	0	0	0	0	10.64	0	0	11.4	0.1	1.1
2025	10	21	7	32	15	0	0	0	0	0	0	0	10.64	0	0	11.4	0.1	1.1
2025	10	21	7	42	15	0	0	0	0	0	0	0	10.64	0	0	11.4	0.1	1.1
2025	10	21	7	52	15	0	0	0	0	0	0	0	10.63	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	21	8	2	15	0	0	0	0	0	0	0	10.63	0	0	11.8	0.1	1.1
2025	10	21	8	12	15	0	0	0	0	0	0	0	10.63	0	0	12	0.1	1.1
2025	10	21	8	22	15	0	0	0	0	0	0	0	10.63	0	0	12.2	0.1	1.1
2025	10	21	8	32	15	0	0	0	0	0	0	0	10.63	0	0	12.4	0.1	1.1
2025	10	21	8	42	15	0	0	0	0	0	0	0	10.66	0	0	12.4	0.1	1.1
2025	10	21	8	52	15	0	0	0	0	0	0	0	10.71	0	0	12.6	0.1	1.1
2025	10	21	9	2	15	0	0	0	0	0	0	0	10.74	0	0	12.6	0.1	1.1
2025	10	21	9	12	15	0	0	0	0	0	0	0	10.76	0	0	12.6	0.1	1.1
2025	10	21	9	22	15	0	0	0	0	0	0	0	10.79	0	0	12.8	0.1	1.1
2025	10	21	9	32	15	0	0	0	0	0	0	0	10.82	0	0	13	0.1	1.1
2025	10	21	9	42	15	0	0	0	0	0	0	0	10.84	0	0	13.2	0.1	1.1
2025	10	21	9	52	15	0	0	0	0	0	0	0	10.87	0	0	13.4	0.1	1.1
2025	10	21	10	2	15	0	0	0	0	0	0	0	10.9	0	0	13.8	0.1	1.1
2025	10	21	10	12	15	0	0	0	0	0	0	0	10.92	0	0	13.8	0.1	1.1
2025	10	21	10	22	15	0	0	0	0	0	0	0	10.95	0	0	13.6	0.1	1.1
2025	10	21	10	32	15	0	0	0	0	0	0	0	10.98	0	0	14.2	0.1	1.1
2025	10	21	10	42	15	0	0	0	0	0	0	0	11.01	0	0	14.2	0.1	1.1
2025	10	21	10	52	15	0	0	0	0	0	0	0	11.03	0	0	14.2	0.1	1.1
2025	10	21	11	2	15	0	0	0	0	0	0	0	11.06	0	0	14.2	0.1	1.1
2025	10	21	11	12	15	0	0	0	0	0	0	0	11.09	0	0	14.2	0.1	1.1
2025	10	21	11	22	15	0	0	0	0	0	0	0	11.1	0	0	14.2	0.1	1.1
2025	10	21	11	32	15	0	0	0	0	0	0	0	11.14	0	0	13.6	0.1	1.1
2025	10	21	11	42	15	0	0	0	0	0	0	0	11.15	0	0	13.6	0.1	1.1
2025	10	21	11	52	15	0	0	0	0	0	0	0	11.18	0	0	13.6	0.1	1.1
2025	10	21	12	2	15	0	0	0	0	0	0	0	11.19	0	0	13.6	0.1	1.1
2025	10	21	12	12	15	0	0	0	0	0	0	0	11.21	0	0	13.6	0.1	1.1
2025	10	21	12	22	15	0	0	0	0	0	0	0	11.24	0	0	13.6	0.1	1.1
2025	10	21	12	32	15	0	0	0	0	0	0	0	11.25	0	0	13.6	0.1	1.1
2025	10	21	12	42	15	0	0	0	0	0	0	0	11.27	0	0	13.6	0.1	1.1
2025	10	21	12	52	15	0	0	0	0	0	0	0	11.28	0	0	13.6	0.1	1.1
2025	10	21	13	2	15	0	0	0	0	0	0	0	11.29	0	0	13.6	0.1	1.1
2025	10	21	13	12	15	0	0	0	0	0	0	0	11.31	0	0	13.6	0.1	1.1
2025	10	21	13	22	15	0	0	0	0	0	0	0	11.33	0	0	13.6	0.1	1.1
2025	10	21	13	32	15	0	0	0	0	0	0	0	11.35	0	0	13.4	0.1	1.1
2025	10	21	13	42	15	0	0	0	0	0	0	0	11.36	0	0	13.4	0.1	1.1
2025	10	21	13	52	15	0	0	0	0	0	0	0	11.36	0	0	13.4	0.1	1.1
2025	10	21	14	2	15	0	0	0	0	0	0	0	11.37	0	0	13.4	0.1	1.1
2025	10	21	14	12	15	0	0	0	0	0	0	0	11.36	0	0	13.4	0.1	1.1
2025	10	21	14	22	15	0	0	0	0	0	0	0	11.37	0	0	13.4	0.1	1.1
2025	10	21	14	32	15	0	0	0	0	0	0	0	11.37	0	0	13.4	0.1	1.1
2025	10	21	14	42	15	0	0	0	0	0	0	0	11.37	0	0	13.4	0.1	1.1
2025	10	21	14	52	15	0	0	0	0	0	0	0	11.37	0	0	13.4	0.1	1.1
2025	10	21	15	2	15	0	0	0	0	0	0	0	11.36	0	0	13.4	0.1	1.1
2025	10	21	15	12	15	0	0	0	0	0	0	0	11.35	0	0	13.4	0.1	1.1
2025	10	21	15	22	15	0	0	0	0	0	0	0	11.37	0	0	13.4	0.1	1.1
2025	10	21	15	32	15	0	0	0	0	0	0	0	11.36	0	0	13.4	0.1	1.1
2025	10	21	15	42	15	0	0	0	0	0	0	0	11.35	0	0	13.4	0.1	1.1
2025	10	21	15	52	15	0	0	0	0	0	0	0	11.33	0	0	13.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	21	16	2	15	0	0	0	0	0	0	0	11.3	0	0	13.4	0.1	1.1
2025	10	21	16	12	15	0	0	0	0	0	0	0	11.28	0	0	13.4	0.1	1.1
2025	10	21	16	22	15	0	0	0	0	0	0	0	11.25	0	0	13.4	0.1	1.1
2025	10	21	16	32	15	0	0	0	0	0	0	0	11.23	0	0	12.6	0.1	1.1
2025	10	21	16	42	15	0	0	0	0	0	0	0	11.23	0	0	12.4	0.1	1.1
2025	10	21	16	52	15	0	0	0	0	0	0	0	11.23	0	0	12.2	0.1	1.1
2025	10	21	17	2	15	0	0	0	0	0	0	0	11.22	0	0	12	0.1	1.1
2025	10	21	17	12	15	0	0	0	0	0	0	0	11.21	0	0	11.8	0.1	1.1
2025	10	21	17	22	15	0	0	0	0	0	0	0	11.21	0	0	11.8	0.1	1.1
2025	10	21	17	32	15	0	0	0	0	0	0	0	11.2	0	0	11.6	0.1	1.1
2025	10	21	17	42	15	0	0	0	0	0	0	0	11.2	0	0	11.6	0.1	1.1
2025	10	21	17	52	15	0	0	0	0	0	0	0	11.19	0	0	11.6	0.1	1.1
2025	10	21	18	2	15	0	0	0	0	0	0	0	11.18	0	0	11.6	0.1	1.1
2025	10	21	18	12	15	0	0	0	0	0	0	0	11.16	0	0	11.6	0.1	1.1
2025	10	21	18	22	15	0	0	0	0	0	0	0	11.15	0	0	11.6	0.1	1.1
2025	10	21	18	32	15	0	0	0	0	0	0	0	11.14	0	0	11.6	0.1	1.1
2025	10	21	18	42	15	0	0	0	0	0	0	0	11.13	0	0	11.6	0.1	1.1
2025	10	21	18	52	15	0	0	0	0	0	0	0	11.11	0	0	11.6	0.1	1.1
2025	10	21	19	2	15	0	0	0	0	0	0	0	11.1	0	0	11.6	0.1	1.1
2025	10	21	19	12	15	0	0	0	0	0	0	0	11.09	0	0	11.6	0.1	1.1
2025	10	21	19	22	15	0	0	0	0	0	0	0	11.07	0	0	11.6	0.1	1.1
2025	10	21	19	32	15	0	0	0	0	0	0	0	11.05	0	0	11.6	0.1	1.1
2025	10	21	19	42	15	0	0	0	0	0	0	0	11.04	0	0	11.6	0.1	1.1
2025	10	21	19	52	15	0	0	0	0	0	0	0	11.03	0	0	11.6	0.1	1.1
2025	10	21	20	2	15	0	0	0	0	0	0	0	11.01	0	0	11.6	0.1	1.1
2025	10	21	20	12	15	0	0	0	0	0	0	0	11	0	0	11.6	0.1	1.1
2025	10	21	20	22	15	0	0	0	0	0	0	0	10.98	0	0	11.6	0.1	1.1
2025	10	21	20	32	15	0	0	0	0	0	0	0	10.96	0	0	11.6	0.1	1.1
2025	10	21	20	42	15	0	0	0	0	0	0	0	10.95	0	0	11.6	0.1	1.1
2025	10	21	20	52	15	0	0	0	0	0	0	0	10.94	0	0	11.6	0.1	1.1
2025	10	21	21	2	15	0	0	0	0	0	0	0	10.93	0	0	11.6	0.1	1.1
2025	10	21	21	12	15	0	0	0	0	0	0	0	10.92	0	0	11.6	0.1	1.1
2025	10	21	21	22	15	0	0	0	0	0	0	0	10.9	0	0	11.6	0.1	1.1
2025	10	21	21	32	15	0	0	0	0	0	0	0	10.9	0	0	11.6	0.1	1.1
2025	10	21	21	42	15	0	0	0	0	0	0	0	10.89	0	0	11.6	0.1	1.1
2025	10	21	21	52	15	0	0	0	0	0	0	0	10.87	0	0	11.6	0.1	1.1
2025	10	21	22	2	15	0	0	0	0	0	0	0	10.86	0	0	11.6	0.1	1.1
2025	10	21	22	12	15	0	0	0	0	0	0	0	10.85	0	0	11.6	0.1	1.1
2025	10	21	22	22	15	0	0	0	0	0	0	0	10.84	0	0	11.6	0.1	1.1
2025	10	21	22	32	15	0	0	0	0	0	0	0	10.84	0	0	11.6	0.1	1.1
2025	10	21	22	42	15	0	0	0	0	0	0	0	10.83	0	0	11.6	0.1	1.1
2025	10	21	22	52	15	0	0	0	0	0	0	0	10.83	0	0	11.6	0.1	1.1
2025	10	21	23	2	15	0	0	0	0	0	0	0	10.82	0	0	11.6	0.1	1.1
2025	10	21	23	12	15	0	0	0	0	0	0	0	10.82	0	0	11.6	0.1	1.1
2025	10	21	23	22	15	0	0	0	0	0	0	0	10.82	0	0	11.6	0.1	1.1
2025	10	21	23	32	15	0	0	0	0	0	0	0	10.82	0	0	11.6	0.1	1.1
2025	10	21	23	42	15	0	0	0	0	0	0	0	10.81	0	0	11.6	0.1	1.1
2025	10	21	23	52	15	0	0	0	0	0	0	0	10.82	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	22	0	2	15	0	0	0	0	0	0	0	10.82	0	0	11.6	0.1	1.1
2025	10	22	0	12	15	0	0	0	0	0	0	0	10.82	0	0	11.6	0.1	1.1
2025	10	22	0	22	15	0	0	0	0	0	0	0	10.82	0	0	11.6	0.1	1.1
2025	10	22	0	32	15	0	0	0	0	0	0	0	10.83	0	0	11.6	0.1	1.1
2025	10	22	0	42	15	0	0	0	0	0	0	0	10.83	0	0	11.6	0.1	1.1
2025	10	22	0	52	15	0	0	0	0	0	0	0	10.84	0	0	11.6	0.1	1.1
2025	10	22	1	2	15	0	0	0	0	0	0	0	10.84	0	0	11.6	0.1	1.1
2025	10	22	1	12	15	0	0	0	0	0	0	0	10.85	0	0	11.6	0.1	1.1
2025	10	22	1	22	15	0	0	0	0	0	0	0	10.86	0	0	11.6	0.1	1.1
2025	10	22	1	32	15	0	0	0	0	0	0	0	10.87	0	0	11.6	0.1	1.1
2025	10	22	1	42	15	0	0	0	0	0	0	0	10.88	0	0	11.6	0.1	1.1
2025	10	22	1	52	15	0	0	0	0	0	0	0	10.89	0	0	11.6	0.1	1.1
2025	10	22	2	2	15	0	0	0	0	0	0	0	10.91	0	0	11.6	0.1	1.1
2025	10	22	2	12	15	0	0	0	0	0	0	0	10.92	0	0	11.4	0.1	1.1
2025	10	22	2	22	15	0	0	0	0	0	0	0	10.93	0	0	11.4	0.1	1.1
2025	10	22	2	32	15	0	0	0	0	0	0	0	10.95	0	0	11.4	0.1	1.1
2025	10	22	2	42	15	0	0	0	0	0	0	0	10.96	0	0	11.4	0.1	1.1
2025	10	22	2	52	15	0	0	0	0	0	0	0	10.98	0	0	11.4	0.1	1.1
2025	10	22	3	2	15	0	0	0	0	0	0	0	10.99	0	0	11.4	0.1	1.1
2025	10	22	3	12	15	0	0	0	0	0	0	0	11.01	0	0	11.4	0.1	1.1
2025	10	22	3	22	15	0	0	0	0	0	0	0	11.02	0	0	11.4	0.1	1.1
2025	10	22	3	32	15	0	0	0	0	0	0	0	11.04	0	0	11.4	0.1	1.1
2025	10	22	3	42	15	0	0	0	0	0	0	0	11.05	0	0	11.4	0.1	1.1
2025	10	22	3	52	15	0	0	0	0	0	0	0	11.06	0	0	11.4	0.1	1.1
2025	10	22	4	2	15	0	0	0	0	0	0	0	11.08	0	0	11.4	0.1	1.1
2025	10	22	4	12	15	0	0	0	0	0	0	0	11.1	0	0	11.4	0.1	1.1
2025	10	22	4	22	15	0	0	0	0	0	0	0	11.11	0	0	11.4	0.1	1.1
2025	10	22	4	32	15	0	0	0	0	0	0	0	11.12	0	0	11.4	0.1	1.1
2025	10	22	4	42	15	0	0	0	0	0	0	0	11.14	0	0	11.4	0.1	1.1
2025	10	22	4	52	15	0	0	0	0	0	0	0	11.15	0	0	11.4	0.1	1.1
2025	10	22	5	2	15	0	0	0	0	0	0	0	11.16	0	0	11.4	0.1	1.1
2025	10	22	5	12	15	0	0	0	0	0	0	0	11.18	0	0	11.4	0.1	1.1
2025	10	22	5	22	15	0	0	0	0	0	0	0	11.19	0	0	11.4	0.1	1.1
2025	10	22	5	32	15	0	0	0	0	0	0	0	11.2	0	0	11.4	0.1	1.1
2025	10	22	5	42	15	0	0	0	0	0	0	0	11.22	0	0	11.4	0.1	1.1
2025	10	22	5	52	15	0	0	0	0	0	0	0	11.23	0	0	11.4	0.1	1.1
2025	10	22	6	2	15	0	0	0	0	0	0	0	11.24	0	0	11.4	0.1	1.1
2025	10	22	6	12	15	0	0	0	0	0	0	0	11.26	0	0	11.4	0.1	1.1
2025	10	22	6	22	15	0	0	0	0	0	0	0	11.27	0	0	11.4	0.1	1.1
2025	10	22	6	32	15	0	0	0	0	0	0	0	11.27	0	0	11.4	0.1	1.1
2025	10	22	6	42	15	0	0	0	0	0	0	0	11.29	0	0	11.4	0.1	1.1
2025	10	22	6	52	15	0	0	0	0	0	0	0	11.3	0	0	11.4	0.1	1.1
2025	10	22	7	2	15	0	0	0	0	0	0	0	11.32	0	0	11.4	0.1	1.1
2025	10	22	7	12	15	0	0	0	0	0	0	0	11.33	0	0	11.4	0.1	1.1
2025	10	22	7	22	15	0	0	0	0	0	0	0	11.34	0	0	11.4	0.1	1.1
2025	10	22	7	32	15	0	0	0	0	0	0	0	11.36	0	0	11.4	0.1	1.1
2025	10	22	7	42	15	0	0	0	0	0	0	0	11.38	0	0	11.4	0.1	1.1
2025	10	22	7	52	15	0	0	0	0	0	0	0	11.39	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	22	8	2	15	0	0	0	0	0	0	0	11.39	0	0	11.4	0.1	1.1
2025	10	22	8	12	15	0	0	0	0	0	0	0	11.41	0	0	11.4	0.1	1.1
2025	10	22	8	22	15	0	0	0	0	0	0	0	11.41	0	0	11.4	0.1	1.1
2025	10	22	8	32	15	0	0	0	0	0	0	0	11.43	0	0	11.4	0.1	1.1
2025	10	22	8	42	15	0	0	0	0	0	0	0	11.45	0	0	11.4	0.1	1.1
2025	10	22	8	52	15	0	0	0	0	0	0	0	11.47	0	0	11.6	0.1	1.1
2025	10	22	9	2	15	0	0	0	0	0	0	0	11.49	0	0	11.6	0.1	1.1
2025	10	22	9	12	15	0	0	0	0	0	0	0	11.52	0	0	11.6	0.1	1.1
2025	10	22	9	22	15	0	0	0	0	0	0	0	11.56	0	0	12	0.1	1.1
2025	10	22	9	32	15	0	0	0	0	0	0	0	11.58	0	0	12	0.1	1.1
2025	10	22	9	42	15	0	0	0	0	0	0	0	11.59	0	0	12	0.1	1.1
2025	10	22	9	52	15	0	0	0	0	0	0	0	11.62	0	0	12.2	0.1	1.1
2025	10	22	10	2	15	0	0	0	0	0	0	0	11.6	0	0	12	0.1	1.1
2025	10	22	10	12	15	0	0	0	0	0	0	0	11.62	0	0	12	0.1	1.1
2025	10	22	10	22	15	0	0	0	0	0	0	0	11.62	0	0	12	0.1	1.1
2025	10	22	10	32	15	0	0	0	0	0	0	0	11.63	0	0	12	0.1	1.1
2025	10	22	10	42	15	0	0	0	0	0	0	0	11.65	0	0	12	0.1	1.1
2025	10	22	10	52	15	0	0	0	0	0	0	0	11.66	0	0	12	0.1	1.1
2025	10	22	11	2	15	0	0	0	0	0	0	0	11.83	0	0	12.8	0.1	1.1
2025	10	22	11	12	15	0	0	0	0	0	0	0	11.79	0	0	12.4	0.1	1.1
2025	10	22	11	22	15	0	0	0	0	0	0	0	11.97	0	0	12.8	0.1	1.1
2025	10	22	11	32	15	0	0	0	0	0	0	0	12	0	0	13.4	0.1	1.1
2025	10	22	11	42	15	0	0	0	0	0	0	0	12.04	0	0	13	0.1	1.1
2025	10	22	11	52	15	0	0	0	0	0	0	0	12.08	0	0	13.4	0.1	1.1
2025	10	22	12	2	15	0	0	0	0	0	0	0	12.1	0	0	14.2	0.1	1.1
2025	10	22	12	12	15	0	0	0	0	0	0	0	12.12	0	0	14.2	0.1	1.1
2025	10	22	12	22	15	0	0	0	0	0	0	0	12.15	0	0	14.2	0.1	1.1
2025	10	22	12	32	15	0	0	0	0	0	0	0	12.17	0	0	13.4	0.1	1.1
2025	10	22	12	42	15	0	0	0	0	0	0	0	12.16	0	0	13.6	0.1	1.1
2025	10	22	12	52	15	0	0	0	0	0	0	0	12.08	0	0	13.2	0.1	1.1
2025	10	22	13	2	15	0	0	0	0	0	0	0	12.17	0	0	13.4	0.1	1.1
2025	10	22	13	12	15	0	0	0	0	0	0	0	12.2	0	0	13.4	0.1	1.1
2025	10	22	13	22	15	0	0	0	0	0	0	0	12.21	0	0	13.4	0.1	1.1
2025	10	22	13	32	15	0	0	0	0	0	0	0	12.22	0	0	13.4	0.1	1.1
2025	10	22	13	42	15	0	0	0	0	0	0	0	12.22	0	0	13.4	0.1	1.1
2025	10	22	13	52	15	0	0	0	0	0	0	0	12.12	0	0	13.6	0.1	1.1
2025	10	22	14	2	15	0	0	0	0	0	0	0	12.05	0	0	13.2	0.1	1.1
2025	10	22	14	12	15	0	0	0	0	0	0	0	12	0	0	12.4	0.1	1.1
2025	10	22	14	22	15	0	0	0	0	0	0	0	11.97	0	0	12.6	0.1	1.1
2025	10	22	14	32	15	0	0	0	0	0	0	0	11.98	0	0	12.2	0.1	1.1
2025	10	22	14	42	15	0	0	0	0	0	0	0	11.96	0	0	12	0.1	1.1
2025	10	22	14	52	15	0	0	0	0	0	0	0	11.96	0	0	12	0.1	1.1
2025	10	22	15	2	15	0	0	0	0	0	0	0	11.97	0	0	12.2	0.1	1.1
2025	10	22	15	12	15	0	0	0	0	0	0	0	11.98	0	0	12.2	0.1	1.1
2025	10	22	15	22	15	0	0	0	0	0	0	0	12.03	0	0	13.4	0.1	1.1
2025	10	22	15	32	15	0	0	0	0	0	0	0	12.04	0	0	13.4	0.1	1.1
2025	10	22	15	42	15	0	0	0	0	0	0	0	12	0	0	13.2	0.1	1.1
2025	10	22	15	52	15	0	0	0	0	0	0	0	11.98	0	0	12.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	22	16	2	15	0	0	0	0	0	0	0	11.97	0	0	12	0.1	1.1
2025	10	22	16	12	15	0	0	0	0	0	0	0	11.96	0	0	11.8	0.1	1.1
2025	10	22	16	22	15	0	0	0	0	0	0	0	11.95	0	0	12	0.1	1.1
2025	10	22	16	32	15	0	0	0	0	0	0	0	11.94	0	0	11.6	0.1	1.1
2025	10	22	16	42	15	0	0	0	0	0	0	0	11.93	0	0	11.6	0.1	1.1
2025	10	22	16	52	15	0	0	0	0	0	0	0	11.91	0	0	11.6	0.1	1.1
2025	10	22	17	2	15	0	0	0	0	0	0	0	11.91	0	0	11.2	0.1	1.1
2025	10	22	17	12	15	0	0	0	0	0	0	0	11.89	0	0	11	0.1	1.1
2025	10	22	17	22	15	0	0	0	0	0	0	0	11.88	0	0	11	0.1	1.1
2025	10	22	17	32	15	0	0	0	0	0	0	0	11.87	0	0	11.6	0.1	1.1
2025	10	22	17	42	15	0	0	0	0	0	0	0	11.86	0	0	11.6	0.1	1.1
2025	10	22	17	52	15	0	0	0	0	0	0	0	11.85	0	0	11.4	0.1	1.1
2025	10	22	18	2	15	0	0	0	0	0	0	0	11.85	0	0	11.4	0.1	1.1
2025	10	22	18	12	15	0	0	0	0	0	0	0	11.84	0	0	11.4	0.1	1.1
2025	10	22	18	22	15	0	0	0	0	0	0	0	11.83	0	0	11.4	0.1	1.1
2025	10	22	18	32	15	0	0	0	0	0	0	0	11.83	0	0	11	0.1	1.1
2025	10	22	18	42	15	0	0	0	0	0	0	0	11.82	0	0	11	0.1	1.1
2025	10	22	18	52	15	0	0	0	0	0	0	0	11.82	0	0	11	0.1	1.1
2025	10	22	19	2	15	0	0	0	0	0	0	0	11.81	0	0	10.8	0.1	1.1
2025	10	22	19	12	15	0	0	0	0	0	0	0	11.8	0	0	10.8	0.1	1.1
2025	10	22	19	22	15	0	0	0	0	0	0	0	11.8	0	0	10.8	0.1	1.1
2025	10	22	19	32	15	0	0	0	0	0	0	0	11.79	0	0	11.4	0.1	1.1
2025	10	22	19	42	15	0	0	0	0	0	0	0	11.78	0	0	11.4	0.1	1.1
2025	10	22	19	52	15	0	0	0	0	0	0	0	11.77	0	0	11.4	0.1	1.1
2025	10	22	20	2	15	0	0	0	0	0	0	0	11.76	0	0	11.4	0.1	1.1
2025	10	22	20	12	15	0	0	0	0	0	0	0	11.75	0	0	11.4	0.1	1.1
2025	10	22	20	22	15	0	0	0	0	0	0	0	11.74	0	0	11.4	0.1	1.1
2025	10	22	20	32	15	0	0	0	0	0	0	0	11.73	0	0	11.4	0.1	1.1
2025	10	22	20	42	15	0	0	0	0	0	0	0	11.71	0	0	11.4	0.1	1.1
2025	10	22	20	52	15	0	0	0	0	0	0	0	11.7	0	0	11.4	0.1	1.1
2025	10	22	21	2	15	0	0	0	0	0	0	0	11.69	0	0	11.4	0.1	1.1
2025	10	22	21	12	15	0	0	0	0	0	0	0	11.67	0	0	11.4	0.1	1.1
2025	10	22	21	22	15	0	0	0	0	0	0	0	11.66	0	0	11.4	0.1	1.1
2025	10	22	21	32	15	0	0	0	0	0	0	0	11.65	0	0	11.4	0.1	1.1
2025	10	22	21	42	15	0	0	0	0	0	0	0	11.64	0	0	11.4	0.1	1.1
2025	10	22	21	52	15	0	0	0	0	0	0	0	11.63	0	0	11.4	0.1	1.1
2025	10	22	22	2	15	0	0	0	0	0	0	0	11.62	0	0	11.4	0.1	1.1
2025	10	22	22	12	15	0	0	0	0	0	0	0	11.61	0	0	11.4	0.1	1.1
2025	10	22	22	22	15	0	0	0	0	0	0	0	11.59	0	0	11.4	0.1	1.1
2025	10	22	22	32	15	0	0	0	0	0	0	0	11.59	0	0	11.4	0.1	1.1
2025	10	22	22	42	15	0	0	0	0	0	0	0	11.59	0	0	11.4	0.1	1.1
2025	10	22	22	52	15	0	0	0	0	0	0	0	11.59	0	0	11.4	0.1	1.1
2025	10	22	23	2	15	0	0	0	0	0	0	0	11.59	0	0	11.4	0.1	1.1
2025	10	22	23	12	15	0	0	0	0	0	0	0	11.59	0	0	11.4	0.1	1.1
2025	10	22	23	22	15	0	0	0	0	0	0	0	11.59	0	0	11.4	0.1	1.1
2025	10	22	23	32	15	0	0	0	0	0	0	0	11.59	0	0	11.4	0.1	1.1
2025	10	22	23	42	15	0	0	0	0	0	0	0	11.59	0	0	11.4	0.1	1.1
2025	10	22	23	52	15	0	0	0	0	0	0	0	11.6	0	0	11.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	23	0	2	15	0	0	0	0	0	0	0	11.6	0	0	11.4	0.1	1.1
2025	10	23	0	12	15	0	0	0	0	0	0	0	11.61	0	0	11.4	0.1	1.1
2025	10	23	0	22	15	0	0	0	0	0	0	0	11.61	0	0	11.4	0.1	1.1
2025	10	23	0	32	15	0	0	0	0	0	0	0	11.62	0	0	11.4	0.1	1.1
2025	10	23	0	42	15	0	0	0	0	0	0	0	11.62	0	0	11.4	0.1	1.1
2025	10	23	0	52	15	0	0	0	0	0	0	0	11.62	0	0	11.4	0.1	1.1
2025	10	23	1	2	15	0	0	0	0	0	0	0	11.63	0	0	11.4	0.1	1.1
2025	10	23	1	12	15	0	0	0	0	0	0	0	11.63	0	0	11.4	0.1	1.1
2025	10	23	1	22	15	0	0	0	0	0	0	0	11.63	0	0	11.4	0.1	1.1
2025	10	23	1	32	15	0	0	0	0	0	0	0	11.63	0	0	11.4	0.1	1.1
2025	10	23	1	42	15	0	0	0	0	0	0	0	11.64	0	0	11.4	0.1	1.1
2025	10	23	1	52	15	0	0	0	0	0	0	0	11.65	0	0	11.4	0.1	1.1
2025	10	23	2	2	15	0	0	0	0	0	0	0	11.65	0	0	11.4	0.1	1.1
2025	10	23	2	12	15	0	0	0	0	0	0	0	11.65	0	0	11.4	0.1	1.1
2025	10	23	2	22	15	0	0	0	0	0	0	0	11.66	0	0	11.4	0.1	1.1
2025	10	23	2	32	15	0	0	0	0	0	0	0	11.66	0	0	11.4	0.1	1.1
2025	10	23	2	42	15	0	0	0	0	0	0	0	11.66	0	0	11.4	0.1	1.1
2025	10	23	2	52	15	0	0	0	0	0	0	0	11.67	0	0	11.4	0.1	1.1
2025	10	23	3	2	15	0	0	0	0	0	0	0	11.67	0	0	11.4	0.1	1.1
2025	10	23	3	12	15	0	0	0	0	0	0	0	11.68	0	0	11.4	0.1	1.1
2025	10	23	3	22	15	0	0	0	0	0	0	0	11.69	0	0	11.4	0.1	1.1
2025	10	23	3	32	15	0	0	0	0	0	0	0	11.69	0	0	11.4	0.1	1.1
2025	10	23	3	42	15	0	0	0	0	0	0	0	11.7	0	0	11.4	0.1	1.1
2025	10	23	3	52	15	0	0	0	0	0	0	0	11.71	0	0	11.4	0.1	1.1
2025	10	23	4	2	15	0	0	0	0	0	0	0	11.72	0	0	11.4	0.1	1.1
2025	10	23	4	12	15	0	0	0	0	0	0	0	11.72	0	0	11.4	0.1	1.1
2025	10	23	4	22	15	0	0	0	0	0	0	0	11.73	0	0	11.4	0.1	1.1
2025	10	23	4	32	15	0	0	0	0	0	0	0	11.74	0	0	11.4	0.1	1.1
2025	10	23	4	42	15	0	0	0	0	0	0	0	11.74	0	0	11.4	0.1	1.1
2025	10	23	4	52	15	0	0	0	0	0	0	0	11.76	0	0	11.4	0.1	1.1
2025	10	23	5	2	15	0	0	0	0	0	0	0	11.76	0	0	11.4	0.1	1.1
2025	10	23	5	12	15	0	0	0	0	0	0	0	11.77	0	0	11.4	0.1	1.1
2025	10	23	5	22	15	0	0	0	0	0	0	0	11.78	0	0	11.4	0.1	1.1
2025	10	23	5	32	15	0	0	0	0	0	0	0	11.79	0	0	11.4	0.1	1.1
2025	10	23	5	42	15	0	0	0	0	0	0	0	11.8	0	0	11.4	0.1	1.1
2025	10	23	5	52	15	0	0	0	0	0	0	0	11.81	0	0	11.4	0.1	1.1
2025	10	23	6	2	15	0	0	0	0	0	0	0	11.82	0	0	11.4	0.1	1.1
2025	10	23	6	12	15	0	0	0	0	0	0	0	11.82	0	0	11.4	0.1	1.1
2025	10	23	6	22	15	0	0	0	0	0	0	0	11.83	0	0	11.4	0.1	1.1
2025	10	23	6	32	15	0	0	0	0	0	0	0	11.83	0	0	11.4	0.1	1.1
2025	10	23	6	42	15	0	0	0	0	0	0	0	11.84	0	0	11.4	0.1	1.1
2025	10	23	6	52	15	0	0	0	0	0	0	0	11.84	0	0	11.4	0.1	1.1
2025	10	23	7	2	15	0	0	0	0	0	0	0	11.85	0	0	11.2	0.1	1.1
2025	10	23	7	12	15	0	0	0	0	0	0	0	11.85	0	0	11.4	0.1	1.1
2025	10	23	7	22	15	0	0	0	0	0	0	0	11.85	0	0	11.4	0.1	1.1
2025	10	23	7	32	15	0	0	0	0	0	0	0	11.86	0	0	11.4	0.1	1.1
2025	10	23	7	42	15	0	0	0	0	0	0	0	11.87	0	0	11.4	0.1	1.1
2025	10	23	7	52	15	0	0	0	0	0	0	0	11.87	0	0	11.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	23	8	2	15	0	0	0	0	0	0	0	11.88	0	0	11.6	0.1	1.1
2025	10	23	8	12	15	0	0	0	0	0	0	0	11.88	0	0	11.8	0.1	1.1
2025	10	23	8	22	15	0	0	0	0	0	0	0	11.88	0	0	12	0.1	1.1
2025	10	23	8	32	15	0	0	0	0	0	0	0	11.9	0	0	12.2	0.1	1.1
2025	10	23	8	42	15	0	0	0	0	0	0	0	11.92	0	0	12.2	0.1	1.1
2025	10	23	8	52	15	0	0	0	0	0	0	0	11.97	0	0	12.4	0.1	1.1
2025	10	23	9	2	15	0	0	0	0	0	0	0	12	0	0	12.4	0.1	1.1
2025	10	23	9	12	15	0	0	0	0	0	0	0	12.03	0	0	12.4	0.1	1.1
2025	10	23	9	22	15	0	0	0	0	0	0	0	12.06	0	0	12.4	0.1	1.1
2025	10	23	9	32	15	0	0	0	0	0	0	0	12.08	0	0	12.4	0.1	1.1
2025	10	23	9	42	15	0	0	0	0	0	0	0	12.12	0	0	12.6	0.1	1.1
2025	10	23	9	52	15	0	0	0	0	0	0	0	12.15	0	0	12.6	0.1	1.1
2025	10	23	10	2	15	0	0	0	0	0	0	0	12.18	0	0	12.6	0.1	1.1
2025	10	23	10	12	15	0	0	0	0	0	0	0	12.21	0	0	12.8	0.1	1.1
2025	10	23	10	22	15	0	0	0	0	0	0	0	12.23	0	0	13.2	0.1	1.1
2025	10	23	10	32	15	0	0	0	0	0	0	0	12.26	0	0	13.4	0.1	1.1
2025	10	23	10	42	15	0	0	0	0	0	0	0	12.3	0	0	13.6	0.1	1.1
2025	10	23	10	52	15	0	0	0	0	0	0	0	12.33	0	0	14.2	0.1	1.1
2025	10	23	11	2	15	0	0	0	0	0	0	0	12.36	0	0	14.2	0.1	1.1
2025	10	23	11	12	15	0	0	0	0	0	0	0	12.38	0	0	14.2	0.1	1.1
2025	10	23	11	22	15	0	0	0	0	0	0	0	12.4	0	0	14.2	0.1	1.1
2025	10	23	11	32	15	0	0	0	0	0	0	0	12.43	0	0	14.2	0.1	1.1
2025	10	23	11	42	15	0	0	0	0	0	0	0	12.45	0	0	13.6	0.1	1.1
2025	10	23	11	52	15	0	0	0	0	0	0	0	12.47	0	0	13.6	0.1	1.1
2025	10	23	12	2	15	0	0	0	0	0	0	0	12.5	0	0	14	0.1	1.1
2025	10	23	12	12	15	0	0	0	0	0	0	0	12.52	0	0	13.4	0.1	1.1
2025	10	23	12	22	15	0	0	0	0	0	0	0	12.54	0	0	13.4	0.1	1.1
2025	10	23	12	32	15	0	0	0	0	0	0	0	12.56	0	0	13.4	0.1	1.1
2025	10	23	12	42	15	0	0	0	0	0	0	0	12.58	0	0	13.6	0.1	1.1
2025	10	23	12	52	15	0	0	0	0	0	0	0	12.6	0	0	13.4	0.1	1.1
2025	10	23	13	2	15	0	0	0	0	0	0	0	12.61	0	0	13.4	0.1	1.1
2025	10	23	13	12	15	0	0	0	0	0	0	0	12.7	0	0	13.4	0.1	1.1
2025	10	23	13	22	15	0	0	0	0	0	0	0	12.71	0	0	13.4	0.1	1.1
2025	10	23	13	32	15	0	0	0	0	0	0	0	12.71	0	0	13.4	0.1	1.1
2025	10	23	13	42	15	0	0	0	0	0	0	0	12.73	0	0	13.4	0.1	1.1
2025	10	23	13	52	15	0	0	0	0	0	0	0	12.73	0	0	13.4	0.1	1.1
2025	10	23	14	2	15	0	0	0	0	0	0	0	12.74	0	0	13.4	0.1	1.1
2025	10	23	14	12	15	0	0	0	0	0	0	0	12.74	0	0	13.4	0.1	1.1
2025	10	23	14	22	15	0	0	0	0	0	0	0	12.73	0	0	13.4	0.1	1.1
2025	10	23	14	32	15	0	0	0	0	0	0	0	12.73	0	0	13.4	0.1	1.1
2025	10	23	14	42	15	0	0	0	0	0	0	0	12.71	0	0	13.4	0.1	1.1
2025	10	23	14	52	15	0	0	0	0	0	0	0	12.7	0	0	13.2	0.1	1.1
2025	10	23	15	2	15	0	0	0	0	0	0	0	12.7	0	0	13.2	0.1	1.1
2025	10	23	15	12	15	0	0	0	0	0	0	0	12.68	0	0	13.2	0.1	1.1
2025	10	23	15	22	15	0	0	0	0	0	0	0	12.66	0	0	13.2	0.1	1.1
2025	10	23	15	32	15	0	0	0	0	0	0	0	12.66	0	0	13.2	0.1	1.1
2025	10	23	15	42	15	0	0	0	0	0	0	0	12.64	0	0	13.2	0.1	1.1
2025	10	23	15	52	15	0	0	0	0	0	0	0	12.6	0	0	13.2	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	23	16	2	15	0	0	0	0	0	0	0	12.6	0	0	13.2	0.1	1.1
2025	10	23	16	12	15	0	0	0	0	0	0	0	12.57	0	0	13.2	0.1	1.1
2025	10	23	16	22	15	0	0	0	0	0	0	0	12.54	0	0	12.6	0.1	1.1
2025	10	23	16	32	15	0	0	0	0	0	0	0	12.55	0	0	12.2	0.1	1.1
2025	10	23	16	42	15	0	0	0	0	0	0	0	12.54	0	0	12	0.1	1.1
2025	10	23	16	52	15	0	0	0	0	0	0	0	12.54	0	0	12	0.1	1.1
2025	10	23	17	2	15	0	0	0	0	0	0	0	12.54	0	0	11.8	0.1	1.1
2025	10	23	17	12	15	0	0	0	0	0	0	0	12.54	0	0	11.6	0.1	1.1
2025	10	23	17	22	15	0	0	0	0	0	0	0	12.54	0	0	11.6	0.1	1.1
2025	10	23	17	32	15	0	0	0	0	0	0	0	12.53	0	0	11.4	0.1	1.1
2025	10	23	17	42	15	0	0	0	0	0	0	0	12.53	0	0	11.4	0.1	1.1
2025	10	23	17	52	15	0	0	0	0	0	0	0	12.53	0	0	11.4	0.1	1.1
2025	10	23	18	2	15	0	0	0	0	0	0	0	12.52	0	0	11.4	0.1	1.1
2025	10	23	18	12	15	0	0	0	0	0	0	0	12.52	0	0	11.4	0.1	1.1
2025	10	23	18	22	15	0	0	0	0	0	0	0	12.5	0	0	11.4	0.1	1.1
2025	10	23	18	32	15	0	0	0	0	0	0	0	12.49	0	0	11.4	0.1	1.1
2025	10	23	18	42	15	0	0	0	0	0	0	0	12.49	0	0	11.4	0.1	1.1
2025	10	23	18	52	15	0	0	0	0	0	0	0	12.47	0	0	11.4	0.1	1.1
2025	10	23	19	2	15	0	0	0	0	0	0	0	12.46	0	0	11.4	0.1	1.1
2025	10	23	19	12	15	0	0	0	0	0	0	0	12.45	0	0	11.4	0.1	1.1
2025	10	23	19	22	15	0	0	0	0	0	0	0	12.44	0	0	11.4	0.1	1.1
2025	10	23	19	32	15	0	0	0	0	0	0	0	12.41	0	0	11.4	0.1	1.1
2025	10	23	19	42	15	0	0	0	0	0	0	0	12.4	0	0	11.4	0.1	1.1
2025	10	23	19	52	15	0	0	0	0	0	0	0	12.39	0	0	11.4	0.1	1.1
2025	10	23	20	2	15	0	0	0	0	0	0	0	12.37	0	0	11.4	0.1	1.1
2025	10	23	20	12	15	0	0	0	0	0	0	0	12.35	0	0	11.4	0.1	1.1
2025	10	23	20	22	15	0	0	0	0	0	0	0	12.33	0	0	11.4	0.1	1.1
2025	10	23	20	32	15	0	0	0	0	0	0	0	12.31	0	0	11.4	0.1	1.1
2025	10	23	20	42	15	0	0	0	0	0	0	0	12.3	0	0	11.4	0.1	1.1
2025	10	23	20	52	15	0	0	0	0	0	0	0	12.28	0	0	11.4	0.1	1.1
2025	10	23	21	2	15	0	0	0	0	0	0	0	12.26	0	0	11.4	0.1	1.1
2025	10	23	21	12	15	0	0	0	0	0	0	0	12.24	0	0	11.4	0.1	1.1
2025	10	23	21	22	15	0	0	0	0	0	0	0	12.23	0	0	11.4	0.1	1.1
2025	10	23	21	32	15	0	0	0	0	0	0	0	12.21	0	0	11.4	0.1	1.1
2025	10	23	21	42	15	0	0	0	0	0	0	0	12.2	0	0	11.4	0.1	1.1
2025	10	23	21	52	15	0	0	0	0	0	0	0	12.18	0	0	11.4	0.1	1.1
2025	10	23	22	2	15	0	0	0	0	0	0	0	12.17	0	0	11.4	0.1	1.1
2025	10	23	22	12	15	0	0	0	0	0	0	0	12.15	0	0	11.4	0.1	1.1
2025	10	23	22	22	15	0	0	0	0	0	0	0	12.13	0	0	11.4	0.1	1.1
2025	10	23	22	32	15	0	0	0	0	0	0	0	12.11	0	0	11.4	0.1	1.1
2025	10	23	22	42	15	0	0	0	0	0	0	0	12.09	0	0	11.4	0.1	1.1
2025	10	23	22	52	15	0	0	0	0	0	0	0	12.08	0	0	11.4	0.1	1.1
2025	10	23	23	2	15	0	0	0	0	0	0	0	12.07	0	0	11.4	0.1	1.1
2025	10	23	23	12	15	0	0	0	0	0	0	0	12.05	0	0	11.4	0.1	1.1
2025	10	23	23	22	15	0	0	0	0	0	0	0	12.05	0	0	11.4	0.1	1.1
2025	10	23	23	32	15	0	0	0	0	0	0	0	12.03	0	0	11.4	0.1	1.1
2025	10	23	23	42	15	0	0	0	0	0	0	0	12.02	0	0	11.4	0.1	1.1
2025	10	23	23	52	15	0	0	0	0	0	0	0	12.01	0	0	11.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	24	0	2	15	0	0	0	0	0	0	0	12	0	0	11.4	0.1	1.1
2025	10	24	0	12	15	0	0	0	0	0	0	0	11.99	0	0	11.4	0.1	1.1
2025	10	24	0	22	15	0	0	0	0	0	0	0	11.99	0	0	11.4	0.1	1.1
2025	10	24	0	32	15	0	0	0	0	0	0	0	11.99	0	0	11.4	0.1	1.1
2025	10	24	0	42	15	0	0	0	0	0	0	0	11.98	0	0	11.4	0.1	1.1
2025	10	24	0	52	15	0	0	0	0	0	0	0	11.97	0	0	11.4	0.1	1.1
2025	10	24	1	2	15	0	0	0	0	0	0	0	11.96	0	0	11.4	0.1	1.1
2025	10	24	1	12	15	0	0	0	0	0	0	0	11.95	0	0	11.4	0.1	1.1
2025	10	24	1	22	15	0	0	0	0	0	0	0	11.95	0	0	11.4	0.1	1.1
2025	10	24	1	32	15	0	0	0	0	0	0	0	11.95	0	0	11.4	0.1	1.1
2025	10	24	1	42	15	0	0	0	0	0	0	0	11.94	0	0	11.4	0.1	1.1
2025	10	24	1	52	15	0	0	0	0	0	0	0	11.94	0	0	11.4	0.1	1.1
2025	10	24	2	2	15	0	0	0	0	0	0	0	11.94	0	0	11.4	0.1	1.1
2025	10	24	2	12	15	0	0	0	0	0	0	0	11.94	0	0	11.4	0.1	1.1
2025	10	24	2	22	15	0	0	0	0	0	0	0	11.94	0	0	11.4	0.1	1.1
2025	10	24	2	32	15	0	0	0	0	0	0	0	11.93	0	0	11.4	0.1	1.1
2025	10	24	2	42	15	0	0	0	0	0	0	0	11.94	0	0	11.4	0.1	1.1
2025	10	24	2	52	15	0	0	0	0	0	0	0	11.94	0	0	11.4	0.1	1.1
2025	10	24	3	2	15	0	0	0	0	0	0	0	11.94	0	0	11.4	0.1	1.1
2025	10	24	3	12	15	0	0	0	0	0	0	0	11.94	0	0	11.4	0.1	1.1
2025	10	24	3	22	15	0	0	0	0	0	0	0	11.93	0	0	11.4	0.1	1.1
2025	10	24	3	32	15	0	0	0	0	0	0	0	11.93	0	0	11.4	0.1	1.1
2025	10	24	3	42	15	0	0	0	0	0	0	0	11.94	0	0	11.4	0.1	1.1
2025	10	24	3	52	15	0	0	0	0	0	0	0	11.94	0	0	11.4	0.1	1.1
2025	10	24	4	2	15	0	0	0	0	0	0	0	11.94	0	0	11.4	0.1	1.1
2025	10	24	4	12	15	0	0	0	0	0	0	0	11.94	0	0	11.4	0.1	1.1
2025	10	24	4	22	15	0	0	0	0	0	0	0	11.94	0	0	11.4	0.1	1.1
2025	10	24	4	32	15	0	0	0	0	0	0	0	11.94	0	0	11.4	0.1	1.1
2025	10	24	4	42	15	0	0	0	0	0	0	0	11.94	0	0	11.4	0.1	1.1
2025	10	24	4	52	15	0	0	0	0	0	0	0	11.94	0	0	11.4	0.1	1.1
2025	10	24	5	2	15	0	0	0	0	0	0	0	11.95	0	0	11.4	0.1	1.1
2025	10	24	5	12	15	0	0	0	0	0	0	0	11.94	0	0	11.2	0.1	1.1
2025	10	24	5	22	15	0	0	0	0	0	0	0	11.94	0	0	11.2	0.1	1.1
2025	10	24	5	32	15	0	0	0	0	0	0	0	11.94	0	0	11.2	0.1	1.1
2025	10	24	5	42	15	0	0	0	0	0	0	0	11.94	0	0	11.2	0.1	1.1
2025	10	24	5	52	15	0	0	0	0	0	0	0	11.94	0	0	11.2	0.1	1.1
2025	10	24	6	2	15	0	0	0	0	0	0	0	11.94	0	0	11.2	0.1	1.1
2025	10	24	6	12	15	0	0	0	0	0	0	0	11.94	0	0	11.2	0.1	1.1
2025	10	24	6	22	15	0	0	0	0	0	0	0	11.93	0	0	11.2	0.1	1.1
2025	10	24	6	32	15	0	0	0	0	0	0	0	11.93	0	0	11.2	0.1	1.1
2025	10	24	6	42	15	0	0	0	0	0	0	0	11.93	0	0	11.2	0.1	1.1
2025	10	24	6	52	15	0	0	0	0	0	0	0	11.93	0	0	11.2	0.1	1.1
2025	10	24	7	2	15	0	0	0	0	0	0	0	11.92	0	0	11.2	0.1	1.1
2025	10	24	7	12	15	0	0	0	0	0	0	0	11.92	0	0	11.2	0.1	1.1
2025	10	24	7	22	15	0	0	0	0	0	0	0	11.91	0	0	11.2	0.1	1.1
2025	10	24	7	32	15	0	0	0	0	0	0	0	11.92	0	0	11.2	0.1	1.1
2025	10	24	7	42	15	0	0	0	0	0	0	0	11.92	0	0	11.2	0.1	1.1
2025	10	24	7	52	15	0	0	0	0	0	0	0	11.91	0	0	11.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	24	8	2	15	0	0	0	0	0	0	0	11.91	0	0	11.8	0.1	1.1
2025	10	24	8	12	15	0	0	0	0	0	0	0	11.91	0	0	12	0.1	1.1
2025	10	24	8	22	15	0	0	0	0	0	0	0	11.91	0	0	12.2	0.1	1.1
2025	10	24	8	32	15	0	0	0	0	0	0	0	11.92	0	0	12.2	0.1	1.1
2025	10	24	8	42	15	0	0	0	0	0	0	0	11.97	0	0	12.4	0.1	1.1
2025	10	24	8	52	15	0	0	0	0	0	0	0	12.01	0	0	12.4	0.1	1.1
2025	10	24	9	2	15	0	0	0	0	0	0	0	12.04	0	0	12.4	0.1	1.1
2025	10	24	9	12	15	0	0	0	0	0	0	0	12.07	0	0	12.6	0.1	1.1
2025	10	24	9	22	15	0	0	0	0	0	0	0	12.1	0	0	12.6	0.1	1.1
2025	10	24	9	32	15	0	0	0	0	0	0	0	12.13	0	0	12.6	0.1	1.1
2025	10	24	9	42	15	0	0	0	0	0	0	0	12.16	0	0	12.8	0.1	1.1
2025	10	24	9	52	15	0	0	0	0	0	0	0	12.19	0	0	12.8	0.1	1.1
2025	10	24	10	2	15	0	0	0	0	0	0	0	12.22	0	0	13.2	0.1	1.1
2025	10	24	10	12	15	0	0	0	0	0	0	0	12.26	0	0	13.6	0.1	1.1
2025	10	24	10	22	15	0	0	0	0	0	0	0	12.3	0	0	13.4	0.1	1.1
2025	10	24	10	32	15	0	0	0	0	0	0	0	12.32	0	0	13.6	0.1	1.1
2025	10	24	10	42	15	0	0	0	0	0	0	0	12.36	0	0	13.6	0.1	1.1
2025	10	24	10	52	15	0	0	0	0	0	0	0	12.39	0	0	13.4	0.1	1.1
2025	10	24	11	2	15	0	0	0	0	0	0	0	12.41	0	0	13.2	0.1	1.1
2025	10	24	11	12	15	0	0	0	0	0	0	0	12.45	0	0	13.2	0.1	1.1
2025	10	24	11	22	15	0	0	0	0	0	0	0	12.47	0	0	13.2	0.1	1.1
2025	10	24	11	32	15	0	0	0	0	0	0	0	12.5	0	0	13.2	0.1	1.1
2025	10	24	11	42	15	0	0	0	0	0	0	0	12.52	0	0	13.2	0.1	1.1
2025	10	24	11	52	15	0	0	0	0	0	0	0	12.53	0	0	13.2	0.1	1.1
2025	10	24	12	2	15	0	0	0	0	0	0	0	12.55	0	0	13.2	0.1	1.1
2025	10	24	12	12	15	0	0	0	0	0	0	0	12.58	0	0	13.2	0.1	1.1
2025	10	24	12	22	15	0	0	0	0	0	0	0	12.55	0	0	13	0.1	1.1
2025	10	24	12	32	15	0	0	0	0	0	0	0	12.57	0	0	13.2	0.1	1.1
2025	10	24	12	42	15	0	0	0	0	0	0	0	12.62	0	0	13.4	0.1	1.1
2025	10	24	12	52	15	0	0	0	0	0	0	0	12.6	0	0	13.6	0.1	1.1
2025	10	24	13	2	15	0	0	0	0	0	0	0	12.61	0	0	13.8	0.1	1.1
2025	10	24	13	12	15	0	0	0	0	0	0	0	12.62	0	0	13.2	0.1	1.1
2025	10	24	13	22	15	0	0	0	0	0	0	0	12.63	0	0	13	0.1	1.1
2025	10	24	13	32	15	0	0	0	0	0	0	0	12.63	0	0	13.6	0.1	1.1
2025	10	24	13	42	15	0	0	0	0	0	0	0	12.64	0	0	13.8	0.1	1.1
2025	10	24	13	52	15	0	0	0	0	0	0	0	12.65	0	0	13.6	0.1	1.1
2025	10	24	14	2	15	0	0	0	0	0	0	0	12.64	0	0	13.6	0.1	1.1
2025	10	24	14	12	15	0	0	0	0	0	0	0	12.64	0	0	13.6	0.1	1.1
2025	10	24	14	22	15	0	0	0	0	0	0	0	12.64	0	0	13.6	0.1	1.1
2025	10	24	14	32	15	0	0	0	0	0	0	0	12.64	0	0	13.6	0.1	1.1
2025	10	24	14	42	15	0	0	0	0	0	0	0	12.63	0	0	13.6	0.1	1.1
2025	10	24	14	52	15	0	0	0	0	0	0	0	12.64	0	0	13.6	0.1	1.1
2025	10	24	15	2	15	0	0	0	0	0	0	0	12.62	0	0	13.6	0.1	1.1
2025	10	24	15	12	15	0	0	0	0	0	0	0	12.62	0	0	13.6	0.1	1.1
2025	10	24	15	22	15	0	0	0	0	0	0	0	12.6	0	0	13.8	0.1	1.1
2025	10	24	15	32	15	0	0	0	0	0	0	0	12.6	0	0	13.4	0.1	1.1
2025	10	24	15	42	15	0	0	0	0	0	0	0	12.58	0	0	13.2	0.1	1.1
2025	10	24	15	52	15	0	0	0	0	0	0	0	12.55	0	0	13.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	24	16	2	15	0	0	0	0	0	0	0	12.51	0	0	13.4	0.1	1.1
2025	10	24	16	12	15	0	0	0	0	0	0	0	12.49	0	0	13.2	0.1	1.1
2025	10	24	16	22	15	0	0	0	0	0	0	0	12.48	0	0	13.2	0.1	1.1
2025	10	24	16	32	15	0	0	0	0	0	0	0	12.46	0	0	12.2	0.1	1.1
2025	10	24	16	42	15	0	0	0	0	0	0	0	12.46	0	0	12	0.1	1.1
2025	10	24	16	52	15	0	0	0	0	0	0	0	12.45	0	0	12	0.1	1.1
2025	10	24	17	2	15	0	0	0	0	0	0	0	12.44	0	0	11.8	0.1	1.1
2025	10	24	17	12	15	0	0	0	0	0	0	0	12.44	0	0	11.6	0.1	1.1
2025	10	24	17	22	15	0	0	0	0	0	0	0	12.43	0	0	11.6	0.1	1.1
2025	10	24	17	32	15	0	0	0	0	0	0	0	12.42	0	0	11.4	0.1	1.1
2025	10	24	17	42	15	0	0	0	0	0	0	0	12.41	0	0	11.4	0.1	1.1
2025	10	24	17	52	15	0	0	0	0	0	0	0	12.4	0	0	11.6	0.1	1.1
2025	10	24	18	2	15	0	0	0	0	0	0	0	12.39	0	0	11.6	0.1	1.1
2025	10	24	18	12	15	0	0	0	0	0	0	0	12.37	0	0	11.6	0.1	1.1
2025	10	24	18	22	15	0	0	0	0	0	0	0	12.36	0	0	11.4	0.1	1.1
2025	10	24	18	32	15	0	0	0	0	0	0	0	12.34	0	0	11.2	0.1	1.1
2025	10	24	18	42	15	0	0	0	0	0	0	0	12.32	0	0	11.2	0.1	1.1
2025	10	24	18	52	15	0	0	0	0	0	0	0	12.3	0	0	11.4	0.1	1.1
2025	10	24	19	2	15	0	0	0	0	0	0	0	12.28	0	0	11.4	0.1	1.1
2025	10	24	19	12	15	0	0	0	0	0	0	0	12.25	0	0	11.2	0.1	1.1
2025	10	24	19	22	15	0	0	0	0	0	0	0	12.23	0	0	11.2	0.1	1.1
2025	10	24	19	32	15	0	0	0	0	0	0	0	12.21	0	0	11.2	0.1	1.1
2025	10	24	19	42	15	0	0	0	0	0	0	0	12.18	0	0	11.2	0.1	1.1
2025	10	24	19	52	15	0	0	0	0	0	0	0	12.16	0	0	11.2	0.1	1.1
2025	10	24	20	2	15	0	0	0	0	0	0	0	12.15	0	0	11.2	0.1	1.1
2025	10	24	20	12	15	0	0	0	0	0	0	0	12.12	0	0	11.2	0.1	1.1
2025	10	24	20	22	15	0	0	0	0	0	0	0	12.09	0	0	11.4	0.1	1.1
2025	10	24	20	32	15	0	0	0	0	0	0	0	12.07	0	0	11.4	0.1	1.1
2025	10	24	20	42	15	0	0	0	0	0	0	0	12.05	0	0	11.4	0.1	1.1
2025	10	24	20	52	15	0	0	0	0	0	0	0	12.02	0	0	11.4	0.1	1.1
2025	10	24	21	2	15	0	0	0	0	0	0	0	12	0	0	11.4	0.1	1.1
2025	10	24	21	12	15	0	0	0	0	0	0	0	11.98	0	0	11.4	0.1	1.1
2025	10	24	21	22	15	0	0	0	0	0	0	0	11.96	0	0	11.4	0.1	1.1
2025	10	24	21	32	15	0	0	0	0	0	0	0	11.93	0	0	11.4	0.1	1.1
2025	10	24	21	42	15	0	0	0	0	0	0	0	11.91	0	0	11.4	0.1	1.1
2025	10	24	21	52	15	0	0	0	0	0	0	0	11.89	0	0	11.4	0.1	1.1
2025	10	24	22	2	15	0	0	0	0	0	0	0	11.87	0	0	11.4	0.1	1.1
2025	10	24	22	12	15	0	0	0	0	0	0	0	11.85	0	0	11.4	0.1	1.1
2025	10	24	22	22	15	0	0	0	0	0	0	0	11.82	0	0	11.4	0.1	1.1
2025	10	24	22	32	15	0	0	0	0	0	0	0	11.8	0	0	11.4	0.1	1.1
2025	10	24	22	42	15	0	0	0	0	0	0	0	11.78	0	0	11.4	0.1	1.1
2025	10	24	22	52	15	0	0	0	0	0	0	0	11.76	0	0	11.4	0.1	1.1
2025	10	24	23	2	15	0	0	0	0	0	0	0	11.74	0	0	11.4	0.1	1.1
2025	10	24	23	12	15	0	0	0	0	0	0	0	11.72	0	0	11.2	0.1	1.1
2025	10	24	23	22	15	0	0	0	0	0	0	0	11.7	0	0	11.2	0.1	1.1
2025	10	24	23	32	15	0	0	0	0	0	0	0	11.68	0	0	11.2	0.1	1.1
2025	10	24	23	42	15	0	0	0	0	0	0	0	11.67	0	0	11.2	0.1	1.1
2025	10	24	23	52	15	0	0	0	0	0	0	0	11.66	0	0	11.2	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	25	0	2	15	0	0	0	0	0	0	0	11.65	0	0	11.2	0.1	1.1
2025	10	25	0	12	15	0	0	0	0	0	0	0	11.64	0	0	11.2	0.1	1.1
2025	10	25	0	22	15	0	0	0	0	0	0	0	11.63	0	0	11.2	0.1	1.1
2025	10	25	0	32	15	0	0	0	0	0	0	0	11.62	0	0	11.2	0.1	1.1
2025	10	25	0	42	15	0	0	0	0	0	0	0	11.61	0	0	11.2	0.1	1.1
2025	10	25	0	52	15	0	0	0	0	0	0	0	11.6	0	0	11.2	0.1	1.1
2025	10	25	1	2	15	0	0	0	0	0	0	0	11.6	0	0	11.2	0.1	1.1
2025	10	25	1	12	15	0	0	0	0	0	0	0	11.59	0	0	11.2	0.1	1.1
2025	10	25	1	22	15	0	0	0	0	0	0	0	11.58	0	0	11.2	0.1	1.1
2025	10	25	1	32	15	0	0	0	0	0	0	0	11.58	0	0	11.2	0.1	1.1
2025	10	25	1	42	15	0	0	0	0	0	0	0	11.57	0	0	11.2	0.1	1.1
2025	10	25	1	52	15	0	0	0	0	0	0	0	11.57	0	0	11.2	0.1	1.1
2025	10	25	2	2	15	0	0	0	0	0	0	0	11.57	0	0	11.2	0.1	1.1
2025	10	25	2	12	15	0	0	0	0	0	0	0	11.56	0	0	11.2	0.1	1.1
2025	10	25	2	22	15	0	0	0	0	0	0	0	11.57	0	0	11.2	0.1	1.1
2025	10	25	2	32	15	0	0	0	0	0	0	0	11.57	0	0	11.2	0.1	1.1
2025	10	25	2	42	15	0	0	0	0	0	0	0	11.57	0	0	11.2	0.1	1.1
2025	10	25	2	52	15	0	0	0	0	0	0	0	11.57	0	0	11.2	0.1	1.1
2025	10	25	3	2	15	0	0	0	0	0	0	0	11.57	0	0	11.2	0.1	1.1
2025	10	25	3	12	15	0	0	0	0	0	0	0	11.57	0	0	11.2	0.1	1.1
2025	10	25	3	22	15	0	0	0	0	0	0	0	11.58	0	0	11.2	0.1	1.1
2025	10	25	3	32	15	0	0	0	0	0	0	0	11.58	0	0	11.2	0.1	1.1
2025	10	25	3	42	15	0	0	0	0	0	0	0	11.59	0	0	11.2	0.1	1.1
2025	10	25	3	52	15	0	0	0	0	0	0	0	11.58	0	0	11.2	0.1	1.1
2025	10	25	4	2	15	0	0	0	0	0	0	0	11.58	0	0	11.2	0.1	1.1
2025	10	25	4	12	15	0	0	0	0	0	0	0	11.59	0	0	11.2	0.1	1.1
2025	10	25	4	22	15	0	0	0	0	0	0	0	11.6	0	0	11.2	0.1	1.1
2025	10	25	4	32	15	0	0	0	0	0	0	0	11.6	0	0	11.2	0.1	1.1
2025	10	25	4	42	15	0	0	0	0	0	0	0	11.61	0	0	11.2	0.1	1.1
2025	10	25	4	52	15	0	0	0	0	0	0	0	11.62	0	0	11.2	0.1	1.1
2025	10	25	5	2	15	0	0	0	0	0	0	0	11.62	0	0	11.2	0.1	1.1
2025	10	25	5	12	15	0	0	0	0	0	0	0	11.62	0	0	11.2	0.1	1.1
2025	10	25	5	22	15	0	0	0	0	0	0	0	11.62	0	0	11.2	0.1	1.1
2025	10	25	5	32	15	0	0	0	0	0	0	0	11.63	0	0	11.2	0.1	1.1
2025	10	25	5	42	15	0	0	0	0	0	0	0	11.64	0	0	11.2	0.1	1.1
2025	10	25	5	52	15	0	0	0	0	0	0	0	11.64	0	0	11.2	0.1	1.1
2025	10	25	6	2	15	0	0	0	0	0	0	0	11.65	0	0	11.2	0.1	1.1
2025	10	25	6	12	15	0	0	0	0	0	0	0	11.65	0	0	11.2	0.1	1.1
2025	10	25	6	22	15	0	0	0	0	0	0	0	11.65	0	0	11.2	0.1	1.1
2025	10	25	6	32	15	0	0	0	0	0	0	0	11.65	0	0	11.2	0.1	1.1
2025	10	25	6	42	15	0	0	0	0	0	0	0	11.66	0	0	11.2	0.1	1.1
2025	10	25	6	52	15	0	0	0	0	0	0	0	11.66	0	0	11.2	0.1	1.1
2025	10	25	7	2	15	0	0	0	0	0	0	0	11.66	0	0	11.2	0.1	1.1
2025	10	25	7	12	15	0	0	0	0	0	0	0	11.67	0	0	11.2	0.1	1.1
2025	10	25	7	22	15	0	0	0	0	0	0	0	11.67	0	0	11.2	0.1	1.1
2025	10	25	7	32	15	0	0	0	0	0	0	0	11.68	0	0	11.2	0.1	1.1
2025	10	25	7	42	15	0	0	0	0	0	0	0	11.68	0	0	11.2	0.1	1.1
2025	10	25	7	52	15	0	0	0	0	0	0	0	11.69	0	0	11.2	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	25	8	2	15	0	0	0	0	0	0	0	11.7	0	0	11.2	0.1	1.1
2025	10	25	8	12	15	0	0	0	0	0	0	0	11.7	0	0	11.2	0.1	1.1
2025	10	25	8	22	15	0	0	0	0	0	0	0	11.7	0	0	11.2	0.1	1.1
2025	10	25	8	32	15	0	0	0	0	0	0	0	11.71	0	0	11.2	0.1	1.1
2025	10	25	8	42	15	0	0	0	0	0	0	0	11.72	0	0	11.2	0.1	1.1
2025	10	25	8	52	15	0	0	0	0	0	0	0	11.74	0	0	11.4	0.1	1.1
2025	10	25	9	2	15	0	0	0	0	0	0	0	11.75	0	0	11.2	0.1	1.1
2025	10	25	9	12	15	0	0	0	0	0	0	0	11.75	0	0	11.2	0.1	1.1
2025	10	25	9	22	15	0	0	0	0	0	0	0	11.76	0	0	11.2	0.1	1.1
2025	10	25	9	32	15	0	0	0	0	0	0	0	11.77	0	0	11.2	0.1	1.1
2025	10	25	9	42	15	0	0	0	0	0	0	0	11.78	0	0	11.2	0.1	1.1
2025	10	25	9	52	15	0	0	0	0	0	0	0	11.78	0	0	11.2	0.1	1.1
2025	10	25	10	2	15	0	0	0	0	0	0	0	11.79	0	0	11.2	0.1	1.1
2025	10	25	10	12	15	0	0	0	0	0	0	0	11.79	0	0	11.2	0.1	1.1
2025	10	25	10	22	15	0	0	0	0	0	0	0	11.8	0	0	11.2	0.1	1.1
2025	10	25	10	32	15	0	0	0	0	0	0	0	11.84	0	0	11.6	0.1	1.1
2025	10	25	10	42	15	0	0	0	0	0	0	0	11.9	0	0	12	0.1	1.1
2025	10	25	10	52	15	0	0	0	0	0	0	0	11.93	0	0	12.2	0.1	1.1
2025	10	25	11	2	15	0	0	0	0	0	0	0	11.99	0	0	12.4	0.1	1.1
2025	10	25	11	12	15	0	0	0	0	0	0	0	11.98	0	0	12.2	0.1	1.1
2025	10	25	11	22	15	0	0	0	0	0	0	0	12	0	0	12.2	0.1	1.1
2025	10	25	11	32	15	0	0	0	0	0	0	0	12.08	0	0	12.4	0.1	1.1
2025	10	25	11	42	15	0	0	0	0	0	0	0	12.06	0	0	12.2	0.1	1.1
2025	10	25	11	52	15	0	0	0	0	0	0	0	12.06	0	0	12.4	0.1	1.1
2025	10	25	12	2	15	0	0	0	0	0	0	0	12.15	0	0	12.4	0.1	1.1
2025	10	25	12	12	15	0	0	0	0	0	0	0	12.2	0	0	13.4	0.1	1.1
2025	10	25	12	22	15	0	0	0	0	0	0	0	12.22	0	0	12.8	0.1	1.1
2025	10	25	12	32	15	0	0	0	0	0	0	0	12.16	0	0	13.2	0.1	1.1
2025	10	25	12	42	15	0	0	0	0	0	0	0	12.26	0	0	13.6	0.1	1.1
2025	10	25	12	52	15	0	0	0	0	0	0	0	12.27	0	0	13.4	0.1	1.1
2025	10	25	13	2	15	0	0	0	0	0	0	0	12.22	0	0	13.8	0.1	1.1
2025	10	25	13	12	15	0	0	0	0	0	0	0	12.26	0	0	13.8	0.1	1.1
2025	10	25	13	22	15	0	0	0	0	0	0	0	12.3	0	0	13.6	0.1	1
2025	10	25	13	32	15	0	0	0	0	0	0	0	12.3	0	0	13.6	0.1	1
2025	10	25	13	42	15	0	0	0	0	0	0	0	12.26	0	0	13.6	0.1	1.1
2025	10	25	13	52	15	0	0	0	0	0	0	0	12.3	0	0	13.6	0.1	1
2025	10	25	14	2	15	0	0	0	0	0	0	0	12.26	0	0	13.6	0.1	1
2025	10	25	14	12	15	0	0	0	0	0	0	0	12.26	0	0	13.6	0.1	1
2025	10	25	14	22	15	0	0	0	0	0	0	0	12.28	0	0	13.8	0.1	1
2025	10	25	14	32	15	0	0	0	0	0	0	0	12.29	0	0	13.6	0.1	1
2025	10	25	14	42	15	0	0	0	0	0	0	0	12.28	0	0	13.4	0.1	1
2025	10	25	14	52	15	0	0	0	0	0	0	0	12.27	0	0	13.6	0.1	1
2025	10	25	15	2	15	0	0	0	0	0	0	0	12.26	0	0	13.4	0.1	1
2025	10	25	15	12	15	0	0	0	0	0	0	0	12.23	0	0	13.2	0.1	1
2025	10	25	15	22	15	0	0	0	0	0	0	0	12.21	0	0	13.6	0.1	1
2025	10	25	15	32	15	0	0	0	0	0	0	0	12.22	0	0	12.6	0.1	1
2025	10	25	15	42	15	0	0	0	0	0	0	0	12.19	0	0	12.6	0.1	1
2025	10	25	15	52	15	0	0	0	0	0	0	0	12.17	0	0	13.2	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	25	16	2	15	0	0	0	0	0	0	0	12.13	0	0	12.2	0.1	1
2025	10	25	16	12	15	0	0	0	0	0	0	0	12.11	0	0	12	0.1	1
2025	10	25	16	22	15	0	0	0	0	0	0	0	12.09	0	0	11.4	0.1	1
2025	10	25	16	32	15	0	0	0	0	0	0	0	12.09	0	0	11.8	0.1	1
2025	10	25	16	42	15	0	0	0	0	0	0	0	12.08	0	0	11.8	0.1	1
2025	10	25	16	52	15	0	0	0	0	0	0	0	12.08	0	0	11.6	0.1	1
2025	10	25	17	2	15	0	0	0	0	0	0	0	12.07	0	0	11.6	0.1	1
2025	10	25	17	12	15	0	0	0	0	0	0	0	12.06	0	0	11.6	0.1	1
2025	10	25	17	22	15	0	0	0	0	0	0	0	12.05	0	0	11.4	0.1	1
2025	10	25	17	32	15	0	0	0	0	0	0	0	12.05	0	0	11.4	0.1	1
2025	10	25	17	42	15	0	0	0	0	0	0	0	12.04	0	0	11.4	0.1	1
2025	10	25	17	52	15	0	0	0	0	0	0	0	12.02	0	0	11.4	0.1	1
2025	10	25	18	2	15	0	0	0	0	0	0	0	12.01	0	0	11.4	0.1	1
2025	10	25	18	12	15	0	0	0	0	0	0	0	12	0	0	11.2	0.1	1
2025	10	25	18	22	15	0	0	0	0	0	0	0	11.99	0	0	11.2	0.1	1
2025	10	25	18	32	15	0	0	0	0	0	0	0	11.97	0	0	11.2	0.1	1
2025	10	25	18	42	15	0	0	0	0	0	0	0	11.96	0	0	11.2	0.1	1
2025	10	25	18	52	15	0	0	0	0	0	0	0	11.94	0	0	11.2	0.1	1
2025	10	25	19	2	15	0	0	0	0	0	0	0	11.91	0	0	11.2	0.1	1
2025	10	25	19	12	15	0	0	0	0	0	0	0	11.9	0	0	11.2	0.1	1
2025	10	25	19	22	15	0	0	0	0	0	0	0	11.88	0	0	11.2	0.1	1
2025	10	25	19	32	15	0	0	0	0	0	0	0	11.86	0	0	11.2	0.1	1
2025	10	25	19	42	15	0	0	0	0	0	0	0	11.84	0	0	11.2	0.1	1
2025	10	25	19	52	15	0	0	0	0	0	0	0	11.82	0	0	11.2	0.1	1
2025	10	25	20	2	15	0	0	0	0	0	0	0	11.79	0	0	11.2	0.1	1
2025	10	25	20	12	15	0	0	0	0	0	0	0	11.77	0	0	11	0.1	1
2025	10	25	20	22	15	0	0	0	0	0	0	0	11.74	0	0	11	0.1	1
2025	10	25	20	32	15	0	0	0	0	0	0	0	11.72	0	0	11.2	0.1	1
2025	10	25	20	42	15	0	0	0	0	0	0	0	11.7	0	0	11	0.1	1
2025	10	25	20	52	15	0	0	0	0	0	0	0	11.67	0	0	11	0.1	1
2025	10	25	21	2	15	0	0	0	0	0	0	0	11.65	0	0	11	0.1	1
2025	10	25	21	12	15	0	0	0	0	0	0	0	11.62	0	0	11	0.1	1
2025	10	25	21	22	15	0	0	0	0	0	0	0	11.6	0	0	11	0.1	1
2025	10	25	21	32	15	0	0	0	0	0	0	0	11.57	0	0	11	0.1	1
2025	10	25	21	42	15	0	0	0	0	0	0	0	11.55	0	0	11	0.1	1
2025	10	25	21	52	15	0	0	0	0	0	0	0	11.52	0	0	11	0.1	1
2025	10	25	22	2	15	0	0	0	0	0	0	0	11.49	0	0	11	0.1	1
2025	10	25	22	12	15	0	0	0	0	0	0	0	11.47	0	0	11	0.1	1
2025	10	25	22	22	15	0	0	0	0	0	0	0	11.44	0	0	11	0.1	1
2025	10	25	22	32	15	0	0	0	0	0	0	0	11.42	0	0	11	0.1	1
2025	10	25	22	42	15	0	0	0	0	0	0	0	11.39	0	0	11	0.1	1
2025	10	25	22	52	15	0	0	0	0	0	0	0	11.37	0	0	11	0.1	1
2025	10	25	23	2	15	0	0	0	0	0	0	0	11.34	0	0	11	0.1	1
2025	10	25	23	12	15	0	0	0	0	0	0	0	11.32	0	0	11	0.1	1
2025	10	25	23	22	15	0	0	0	0	0	0	0	11.3	0	0	11	0.1	1
2025	10	25	23	32	15	0	0	0	0	0	0	0	11.28	0	0	11	0.1	1
2025	10	25	23	42	15	0	0	0	0	0	0	0	11.26	0	0	11	0.1	1
2025	10	25	23	52	15	0	0	0	0	0	0	0	11.24	0	0	11	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	26	0	2	15	0	0	0	0	0	0	0	11.23	0	0	11	0.1	1
2025	10	26	0	12	15	0	0	0	0	0	0	0	11.21	0	0	11	0.1	1
2025	10	26	0	22	15	0	0	0	0	0	0	0	11.2	0	0	11	0.1	1
2025	10	26	0	32	15	0	0	0	0	0	0	0	11.19	0	0	11	0.1	1
2025	10	26	0	42	15	0	0	0	0	0	0	0	11.19	0	0	11	0.1	1
2025	10	26	0	52	15	0	0	0	0	0	0	0	11.17	0	0	11	0.1	1
2025	10	26	1	2	15	0	0	0	0	0	0	0	11.16	0	0	11	0.1	1
2025	10	26	1	12	15	0	0	0	0	0	0	0	11.15	0	0	11	0.1	1
2025	10	26	1	22	15	0	0	0	0	0	0	0	11.15	0	0	11	0.1	1
2025	10	26	1	32	15	0	0	0	0	0	0	0	11.14	0	0	11	0.1	1
2025	10	26	1	42	15	0	0	0	0	0	0	0	11.14	0	0	11	0.1	1
2025	10	26	1	52	15	0	0	0	0	0	0	0	11.14	0	0	11	0.1	1
2025	10	26	2	2	15	0	0	0	0	0	0	0	11.13	0	0	11	0.1	1
2025	10	26	2	12	15	0	0	0	0	0	0	0	11.13	0	0	11	0.1	1
2025	10	26	2	22	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1
2025	10	26	2	32	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1
2025	10	26	2	42	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1
2025	10	26	2	52	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1
2025	10	26	3	2	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1
2025	10	26	3	12	15	0	0	0	0	0	0	0	11.12	0	0	10.8	0.1	1
2025	10	26	3	22	15	0	0	0	0	0	0	0	11.12	0	0	10.8	0.1	1
2025	10	26	3	32	15	0	0	0	0	0	0	0	11.12	0	0	10.8	0.1	1
2025	10	26	3	42	15	0	0	0	0	0	0	0	11.12	0	0	10.8	0.1	1
2025	10	26	3	52	15	0	0	0	0	0	0	0	11.12	0	0	10.8	0.1	1
2025	10	26	4	2	15	0	0	0	0	0	0	0	11.12	0	0	10.8	0.1	1
2025	10	26	4	12	15	0	0	0	0	0	0	0	11.12	0	0	10.8	0.1	1
2025	10	26	4	22	15	0	0	0	0	0	0	0	11.12	0	0	10.8	0.1	1
2025	10	26	4	32	15	0	0	0	0	0	0	0	11.12	0	0	10.8	0.1	1
2025	10	26	4	42	15	0	0	0	0	0	0	0	11.12	0	0	10.8	0.1	1
2025	10	26	4	52	15	0	0	0	0	0	0	0	11.12	0	0	10.8	0.1	1
2025	10	26	5	2	15	0	0	0	0	0	0	0	11.12	0	0	10.8	0.1	1
2025	10	26	5	12	15	0	0	0	0	0	0	0	11.12	0	0	10.8	0.1	1
2025	10	26	5	22	15	0	0	0	0	0	0	0	11.13	0	0	10.8	0.1	1
2025	10	26	5	32	15	0	0	0	0	0	0	0	11.12	0	0	10.8	0.1	1
2025	10	26	5	42	15	0	0	0	0	0	0	0	11.12	0	0	10.8	0.1	1
2025	10	26	5	52	15	0	0	0	0	0	0	0	11.12	0	0	10.8	0.1	1
2025	10	26	6	2	15	0	0	0	0	0	0	0	11.12	0	0	10.8	0.1	1
2025	10	26	6	12	15	0	0	0	0	0	0	0	11.12	0	0	10.8	0.1	1
2025	10	26	6	22	15	0	0	0	0	0	0	0	11.12	0	0	10.8	0.1	1
2025	10	26	6	32	15	0	0	0	0	0	0	0	11.13	0	0	10.8	0.1	1
2025	10	26	6	42	15	0	0	0	0	0	0	0	11.13	0	0	10.8	0.1	1
2025	10	26	6	52	15	0	0	0	0	0	0	0	11.13	0	0	10.8	0.1	1
2025	10	26	7	2	15	0	0	0	0	0	0	0	11.13	0	0	10.8	0.1	1
2025	10	26	7	12	15	0	0	0	0	0	0	0	11.14	0	0	10.8	0.1	1
2025	10	26	7	22	15	0	0	0	0	0	0	0	11.14	0	0	10.8	0.1	1
2025	10	26	7	32	15	0	0	0	0	0	0	0	11.14	0	0	10.8	0.1	1
2025	10	26	7	42	15	0	0	0	0	0	0	0	11.14	0	0	10.8	0.1	1
2025	10	26	7	52	15	0	0	0	0	0	0	0	11.16	0	0	10.8	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	26	8	2	15	0	0	0	0	0	0	0	11.16	0	0	11	0.1	1
2025	10	26	8	12	15	0	0	0	0	0	0	0	11.17	0	0	11	0.1	1
2025	10	26	8	22	15	0	0	0	0	0	0	0	11.18	0	0	11	0.1	1
2025	10	26	8	32	15	0	0	0	0	0	0	0	11.19	0	0	11	0.1	1
2025	10	26	8	42	15	0	0	0	0	0	0	0	11.21	0	0	11.2	0.1	1
2025	10	26	8	52	15	0	0	0	0	0	0	0	11.22	0	0	11.2	0.1	1
2025	10	26	9	2	15	0	0	0	0	0	0	0	11.24	0	0	11.4	0.1	1
2025	10	26	9	12	15	0	0	0	0	0	0	0	11.26	0	0	11.6	0.1	1
2025	10	26	9	22	15	0	0	0	0	0	0	0	11.29	0	0	11.8	0.1	1
2025	10	26	9	32	15	0	0	0	0	0	0	0	11.33	0	0	12	0.1	1
2025	10	26	9	42	15	0	0	0	0	0	0	0	11.38	0	0	12.2	0.1	1
2025	10	26	9	52	15	0	0	0	0	0	0	0	11.46	0	0	12.6	0.1	1
2025	10	26	10	2	15	0	0	0	0	0	0	0	11.5	0	0	12.6	0.1	1
2025	10	26	10	12	15	0	0	0	0	0	0	0	11.54	0	0	12.6	0.1	1
2025	10	26	10	22	15	0	0	0	0	0	0	0	11.53	0	0	12.2	0.1	1
2025	10	26	10	32	15	0	0	0	0	0	0	0	11.5	0	0	12	0.1	1
2025	10	26	10	42	15	0	0	0	0	0	0	0	11.57	0	0	12.6	0.1	1
2025	10	26	10	52	15	0	0	0	0	0	0	0	11.62	0	0	12.8	0.1	1
2025	10	26	11	2	15	0	0	0	0	0	0	0	11.65	0	0	13.2	0.1	1
2025	10	26	11	12	15	0	0	0	0	0	0	0	11.67	0	0	13.2	0.1	1
2025	10	26	11	22	15	0	0	0	0	0	0	0	11.7	0	0	13.2	0.1	1
2025	10	26	11	32	15	0	0	0	0	0	0	0	11.72	0	0	13.2	0.1	1
2025	10	26	11	42	15	0	0	0	0	0	0	0	11.75	0	0	13.2	0.1	1
2025	10	26	11	52	15	0	0	0	0	0	0	0	11.77	0	0	13.2	0.1	1
2025	10	26	12	2	15	0	0	0	0	0	0	0	11.79	0	0	13.2	0.1	1
2025	10	26	12	12	15	0	0	0	0	0	0	0	11.82	0	0	13.2	0.1	1
2025	10	26	12	22	15	0	0	0	0	0	0	0	11.83	0	0	13.2	0.1	1
2025	10	26	12	32	15	0	0	0	0	0	0	0	11.91	0	0	13.2	0.1	1
2025	10	26	12	42	15	0	0	0	0	0	0	0	11.95	0	0	13.2	0.1	1
2025	10	26	12	52	15	0	0	0	0	0	0	0	11.94	0	0	13.2	0.1	1
2025	10	26	13	2	15	0	0	0	0	0	0	0	11.92	0	0	13.2	0.1	1
2025	10	26	13	12	15	0	0	0	0	0	0	0	11.9	0	0	13.2	0.1	1
2025	10	26	13	22	15	0	0	0	0	0	0	0	11.86	0	0	13.2	0.1	1
2025	10	26	13	32	15	0	0	0	0	0	0	0	11.83	0	0	13.2	0.1	1
2025	10	26	13	42	15	0	0	0	0	0	0	0	11.82	0	0	13.2	0.1	1
2025	10	26	13	52	15	0	0	0	0	0	0	0	11.85	0	0	13.2	0.1	1
2025	10	26	14	2	15	0	0	0	0	0	0	0	11.95	0	0	13.2	0.1	1
2025	10	26	14	12	15	0	0	0	0	0	0	0	12	0	0	13.2	0.1	1
2025	10	26	14	22	15	0	0	0	0	0	0	0	12.02	0	0	13.2	0.1	1
2025	10	26	14	32	15	0	0	0	0	0	0	0	12.03	0	0	12.8	0.1	1
2025	10	26	14	42	15	0	0	0	0	0	0	0	12.03	0	0	12.8	0.1	1
2025	10	26	14	52	15	0	0	0	0	0	0	0	12.03	0	0	12.8	0.1	1
2025	10	26	15	2	15	0	0	0	0	0	0	0	12.01	0	0	12.8	0.1	1
2025	10	26	15	12	15	0	0	0	0	0	0	0	12	0	0	12.6	0.1	1
2025	10	26	15	22	15	0	0	0	0	0	0	0	11.99	0	0	12.6	0.1	1
2025	10	26	15	32	15	0	0	0	0	0	0	0	11.98	0	0	12.6	0.1	1
2025	10	26	15	42	15	0	0	0	0	0	0	0	11.97	0	0	12.6	0.1	1
2025	10	26	15	52	15	0	0	0	0	0	0	0	11.92	0	0	12.6	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	26	16	2	15	0	0	0	0	0	0	0	11.89	0	0	12.6	0.1	1
2025	10	26	16	12	15	0	0	0	0	0	0	0	11.88	0	0	12.6	0.1	1
2025	10	26	16	22	15	0	0	0	0	0	0	0	11.86	0	0	12.6	0.1	1
2025	10	26	16	32	15	0	0	0	0	0	0	0	11.85	0	0	12.4	0.1	1
2025	10	26	16	42	15	0	0	0	0	0	0	0	11.84	0	0	11.8	0.1	1
2025	10	26	16	52	15	0	0	0	0	0	0	0	11.83	0	0	11.6	0.1	1
2025	10	26	17	2	15	0	0	0	0	0	0	0	11.82	0	0	11.6	0.1	1
2025	10	26	17	12	15	0	0	0	0	0	0	0	11.82	0	0	11.4	0.1	1
2025	10	26	17	22	15	0	0	0	0	0	0	0	11.81	0	0	11.2	0.1	1
2025	10	26	17	32	15	0	0	0	0	0	0	0	11.81	0	0	11.2	0.1	1
2025	10	26	17	42	15	0	0	0	0	0	0	0	11.8	0	0	11.2	0.1	1
2025	10	26	17	52	15	0	0	0	0	0	0	0	11.79	0	0	11.2	0.1	1
2025	10	26	18	2	15	0	0	0	0	0	0	0	11.78	0	0	11.2	0.1	1
2025	10	26	18	12	15	0	0	0	0	0	0	0	11.77	0	0	11	0.1	1
2025	10	26	18	22	15	0	0	0	0	0	0	0	11.76	0	0	11.2	0.1	1
2025	10	26	18	32	15	0	0	0	0	0	0	0	11.75	0	0	11.2	0.1	1
2025	10	26	18	42	15	0	0	0	0	0	0	0	11.73	0	0	11.2	0.1	1
2025	10	26	18	52	15	0	0	0	0	0	0	0	11.72	0	0	11.2	0.1	1
2025	10	26	19	2	15	0	0	0	0	0	0	0	11.71	0	0	11.2	0.1	1
2025	10	26	19	12	15	0	0	0	0	0	0	0	11.69	0	0	11.2	0.1	1
2025	10	26	19	22	15	0	0	0	0	0	0	0	11.68	0	0	11.2	0.1	1
2025	10	26	19	32	15	0	0	0	0	0	0	0	11.64	0	0	11.2	0.1	1
2025	10	26	19	42	15	0	0	0	0	0	0	0	11.63	0	0	11.2	0.1	1
2025	10	26	19	52	15	0	0	0	0	0	0	0	11.62	0	0	11	0.1	1
2025	10	26	20	2	15	0	0	0	0	0	0	0	11.6	0	0	11	0.1	1
2025	10	26	20	12	15	0	0	0	0	0	0	0	11.58	0	0	11	0.1	1
2025	10	26	20	22	15	0	0	0	0	0	0	0	11.57	0	0	11	0.1	1
2025	10	26	20	32	15	0	0	0	0	0	0	0	11.55	0	0	11	0.1	1
2025	10	26	20	42	15	0	0	0	0	0	0	0	11.53	0	0	11	0.1	1
2025	10	26	20	52	15	0	0	0	0	0	0	0	11.51	0	0	11	0.1	1
2025	10	26	21	2	15	0	0	0	0	0	0	0	11.5	0	0	11	0.1	1
2025	10	26	21	12	15	0	0	0	0	0	0	0	11.48	0	0	11	0.1	1
2025	10	26	21	22	15	0	0	0	0	0	0	0	11.47	0	0	11	0.1	1
2025	10	26	21	32	15	0	0	0	0	0	0	0	11.45	0	0	11	0.1	1
2025	10	26	21	42	15	0	0	0	0	0	0	0	11.42	0	0	11	0.1	1
2025	10	26	21	52	15	0	0	0	0	0	0	0	11.41	0	0	11	0.1	1
2025	10	26	22	2	15	0	0	0	0	0	0	0	11.39	0	0	11	0.1	1
2025	10	26	22	12	15	0	0	0	0	0	0	0	11.37	0	0	11	0.1	1
2025	10	26	22	22	15	0	0	0	0	0	0	0	11.35	0	0	11	0.1	1
2025	10	26	22	32	15	0	0	0	0	0	0	0	11.33	0	0	11	0.1	1
2025	10	26	22	42	15	0	0	0	0	0	0	0	11.31	0	0	11	0.1	1
2025	10	26	22	52	15	0	0	0	0	0	0	0	11.3	0	0	11	0.1	1
2025	10	26	23	2	15	0	0	0	0	0	0	0	11.28	0	0	11	0.1	1
2025	10	26	23	12	15	0	0	0	0	0	0	0	11.26	0	0	11	0.1	1
2025	10	26	23	22	15	0	0	0	0	0	0	0	11.25	0	0	11	0.1	1
2025	10	26	23	32	15	0	0	0	0	0	0	0	11.23	0	0	11	0.1	1
2025	10	26	23	42	15	0	0	0	0	0	0	0	11.22	0	0	11	0.1	1
2025	10	26	23	52	15	0	0	0	0	0	0	0	11.2	0	0	11	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	27	0	2	15	0	0	0	0	0	0	0	11.19	0	0	11	0.1	1
2025	10	27	0	12	15	0	0	0	0	0	0	0	11.18	0	0	11	0.1	1
2025	10	27	0	22	15	0	0	0	0	0	0	0	11.16	0	0	11	0.1	1
2025	10	27	0	32	15	0	0	0	0	0	0	0	11.15	0	0	11	0.1	1
2025	10	27	0	42	15	0	0	0	0	0	0	0	11.15	0	0	11	0.1	1
2025	10	27	0	52	15	0	0	0	0	0	0	0	11.14	0	0	11	0.1	1
2025	10	27	1	2	15	0	0	0	0	0	0	0	11.13	0	0	11	0.1	1
2025	10	27	1	12	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1
2025	10	27	1	22	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1
2025	10	27	1	32	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1
2025	10	27	1	42	15	0	0	0	0	0	0	0	11.11	0	0	11	0.1	1
2025	10	27	1	52	15	0	0	0	0	0	0	0	11.11	0	0	11	0.1	1
2025	10	27	2	2	15	0	0	0	0	0	0	0	11.11	0	0	11	0.1	1
2025	10	27	2	12	15	0	0	0	0	0	0	0	11.11	0	0	11	0.1	1
2025	10	27	2	22	15	0	0	0	0	0	0	0	11.1	0	0	11	0.1	1
2025	10	27	2	32	15	0	0	0	0	0	0	0	11.11	0	0	11	0.1	1
2025	10	27	2	42	15	0	0	0	0	0	0	0	11.1	0	0	11	0.1	1
2025	10	27	2	52	15	0	0	0	0	0	0	0	11.11	0	0	11	0.1	1
2025	10	27	3	2	15	0	0	0	0	0	0	0	11.11	0	0	11	0.1	1
2025	10	27	3	12	15	0	0	0	0	0	0	0	11.11	0	0	11	0.1	1
2025	10	27	3	22	15	0	0	0	0	0	0	0	11.11	0	0	11	0.1	1
2025	10	27	3	32	15	0	0	0	0	0	0	0	11.11	0	0	11	0.1	1
2025	10	27	3	42	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1
2025	10	27	3	52	15	0	0	0	0	0	0	0	11.11	0	0	11	0.1	1
2025	10	27	4	2	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1
2025	10	27	4	12	15	0	0	0	0	0	0	0	11.11	0	0	11	0.1	1
2025	10	27	4	22	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1
2025	10	27	4	32	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1
2025	10	27	4	42	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1
2025	10	27	4	52	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1
2025	10	27	5	2	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1
2025	10	27	5	12	15	0	0	0	0	0	0	0	11.13	0	0	11	0.1	1
2025	10	27	5	22	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1
2025	10	27	5	32	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1
2025	10	27	5	42	15	0	0	0	0	0	0	0	11.13	0	0	11	0.1	1
2025	10	27	5	52	15	0	0	0	0	0	0	0	11.13	0	0	11	0.1	1
2025	10	27	6	2	15	0	0	0	0	0	0	0	11.13	0	0	11	0.1	1
2025	10	27	6	12	15	0	0	0	0	0	0	0	11.13	0	0	11	0.1	1
2025	10	27	6	22	15	0	0	0	0	0	0	0	11.14	0	0	11	0.1	1
2025	10	27	6	32	15	0	0	0	0	0	0	0	11.14	0	0	11	0.1	1
2025	10	27	6	42	15	0	0	0	0	0	0	0	11.13	0	0	11	0.1	1
2025	10	27	6	52	15	0	0	0	0	0	0	0	11.14	0	0	11	0.1	1
2025	10	27	7	2	15	0	0	0	0	0	0	0	11.14	0	0	11	0.1	1
2025	10	27	7	12	15	0	0	0	0	0	0	0	11.15	0	0	11	0.1	1
2025	10	27	7	22	15	0	0	0	0	0	0	0	11.15	0	0	11	0.1	1
2025	10	27	7	32	15	0	0	0	0	0	0	0	11.16	0	0	11	0.1	1
2025	10	27	7	42	15	0	0	0	0	0	0	0	11.16	0	0	11	0.1	1
2025	10	27	7	52	15	0	0	0	0	0	0	0	11.16	0	0	11	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	27	8	2	15	0	0	0	0	0	0	0	11.17	0	0	11.4	0.1	1
2025	10	27	8	12	15	0	0	0	0	0	0	0	11.17	0	0	11.6	0.1	1
2025	10	27	8	22	15	0	0	0	0	0	0	0	11.18	0	0	11.8	0.1	1
2025	10	27	8	32	15	0	0	0	0	0	0	0	11.19	0	0	12	0.1	1
2025	10	27	8	42	15	0	0	0	0	0	0	0	11.22	0	0	12	0.1	1
2025	10	27	8	52	15	0	0	0	0	0	0	0	11.25	0	0	12	0.1	1
2025	10	27	9	2	15	0	0	0	0	0	0	0	11.28	0	0	12.2	0.1	1
2025	10	27	9	12	15	0	0	0	0	0	0	0	11.31	0	0	12.2	0.1	1
2025	10	27	9	22	15	0	0	0	0	0	0	0	11.34	0	0	12.4	0.1	1
2025	10	27	9	32	15	0	0	0	0	0	0	0	11.36	0	0	12.4	0.1	1
2025	10	27	9	42	15	0	0	0	0	0	0	0	11.39	0	0	12.4	0.1	1
2025	10	27	9	52	15	0	0	0	0	0	0	0	11.43	0	0	12.4	0.1	1
2025	10	27	10	2	15	0	0	0	0	0	0	0	11.45	0	0	12.6	0.1	1
2025	10	27	10	12	15	0	0	0	0	0	0	0	11.48	0	0	13	0.1	1
2025	10	27	10	22	15	0	0	0	0	0	0	0	11.51	0	0	13.2	0.1	1
2025	10	27	10	32	15	0	0	0	0	0	0	0	11.54	0	0	12.8	0.1	1
2025	10	27	10	42	15	0	0	0	0	0	0	0	11.57	0	0	12.8	0.1	1
2025	10	27	10	52	15	0	0	0	0	0	0	0	11.6	0	0	13.6	0.1	1
2025	10	27	11	2	15	0	0	0	0	0	0	0	11.63	0	0	13.6	0.1	1
2025	10	27	11	12	15	0	0	0	0	0	0	0	11.66	0	0	13.8	0.1	1
2025	10	27	11	22	15	0	0	0	0	0	0	0	11.69	0	0	13.8	0.1	1
2025	10	27	11	32	15	0	0	0	0	0	0	0	11.71	0	0	13.8	0.1	1
2025	10	27	11	42	15	0	0	0	0	0	0	0	11.76	0	0	14	0.1	1
2025	10	27	11	52	15	0	0	0	0	0	0	0	11.82	0	0	14	0.1	1
2025	10	27	12	2	15	0	0	0	0	0	0	0	11.82	0	0	13.8	0.1	1
2025	10	27	12	12	15	0	0	0	0	0	0	0	11.85	0	0	14	0.1	1
2025	10	27	12	22	15	0	0	0	0	0	0	0	11.87	0	0	14	0.1	1
2025	10	27	12	32	15	0	0	0	0	0	0	0	11.88	0	0	13.8	0.1	1
2025	10	27	12	42	15	0	0	0	0	0	0	0	11.89	0	0	14	0.1	1
2025	10	27	12	52	15	0	0	0	0	0	0	0	11.91	0	0	13.8	0.1	1
2025	10	27	13	2	15	0	0	0	0	0	0	0	11.92	0	0	13.8	0.1	1
2025	10	27	13	12	15	0	0	0	0	0	0	0	11.94	0	0	13.8	0.1	1
2025	10	27	13	22	15	0	0	0	0	0	0	0	11.94	0	0	13.8	0.1	1
2025	10	27	13	32	15	0	0	0	0	0	0	0	11.94	0	0	14	0.1	1
2025	10	27	13	42	15	0	0	0	0	0	0	0	12.05	0	0	14.2	0.1	1
2025	10	27	13	52	15	0	0	0	0	0	0	0	12.06	0	0	14.2	0.1	1
2025	10	27	14	2	15	0	0	0	0	0	0	0	12.05	0	0	14	0.1	1
2025	10	27	14	12	15	0	0	0	0	0	0	0	12.04	0	0	14	0.1	1
2025	10	27	14	22	15	0	0	0	0	0	0	0	12.03	0	0	14	0.1	1
2025	10	27	14	32	15	0	0	0	0	0	0	0	12.02	0	0	13.8	0.1	1
2025	10	27	14	42	15	0	0	0	0	0	0	0	11.98	0	0	13.8	0.1	1
2025	10	27	14	52	15	0	0	0	0	0	0	0	11.96	0	0	13.8	0.1	1
2025	10	27	15	2	15	0	0	0	0	0	0	0	11.95	0	0	13.8	0.1	1
2025	10	27	15	12	15	0	0	0	0	0	0	0	11.95	0	0	13.8	0.1	1
2025	10	27	15	22	15	0	0	0	0	0	0	0	11.93	0	0	13.6	0.1	1
2025	10	27	15	32	15	0	0	0	0	0	0	0	11.92	0	0	13.6	0.1	1
2025	10	27	15	42	15	0	0	0	0	0	0	0	11.9	0	0	13.4	0.1	1
2025	10	27	15	52	15	0	0	0	0	0	0	0	11.86	0	0	13.4	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	27	16	2	15	0	0	0	0	0	0	0	11.84	0	0	13.4	0.1	1
2025	10	27	16	12	15	0	0	0	0	0	0	0	11.82	0	0	13.4	0.1	1
2025	10	27	16	22	15	0	0	0	0	0	0	0	11.81	0	0	13.2	0.1	1
2025	10	27	16	32	15	0	0	0	0	0	0	0	11.79	0	0	12.6	0.1	1
2025	10	27	16	42	15	0	0	0	0	0	0	0	11.79	0	0	12.2	0.1	1
2025	10	27	16	52	15	0	0	0	0	0	0	0	11.78	0	0	12	0.1	1
2025	10	27	17	2	15	0	0	0	0	0	0	0	11.77	0	0	11.6	0.1	1
2025	10	27	17	12	15	0	0	0	0	0	0	0	11.76	0	0	11.4	0.1	1
2025	10	27	17	22	15	0	0	0	0	0	0	0	11.75	0	0	11	0.1	1
2025	10	27	17	32	15	0	0	0	0	0	0	0	11.74	0	0	10.8	0.1	1
2025	10	27	17	42	15	0	0	0	0	0	0	0	11.72	0	0	10.8	0.1	1
2025	10	27	17	52	15	0	0	0	0	0	0	0	11.71	0	0	10.6	0.1	1
2025	10	27	18	2	15	0	0	0	0	0	0	0	11.69	0	0	10.4	0.1	1
2025	10	27	18	12	15	0	0	0	0	0	0	0	11.68	0	0	10.4	0.1	1
2025	10	27	18	22	15	0	0	0	0	0	0	0	11.66	0	0	10.4	0.1	1
2025	10	27	18	32	15	0	0	0	0	0	0	0	11.64	0	0	11.2	0.1	1
2025	10	27	18	42	15	0	0	0	0	0	0	0	11.62	0	0	11.2	0.1	1
2025	10	27	18	52	15	0	0	0	0	0	0	0	11.59	0	0	11.2	0.1	1
2025	10	27	19	2	15	0	0	0	0	0	0	0	11.57	0	0	11.2	0.1	1
2025	10	27	19	12	15	0	0	0	0	0	0	0	11.55	0	0	11.2	0.1	1
2025	10	27	19	22	15	0	0	0	0	0	0	0	11.52	0	0	11.2	0.1	1
2025	10	27	19	32	15	0	0	0	0	0	0	0	11.5	0	0	11.2	0.1	1
2025	10	27	19	42	15	0	0	0	0	0	0	0	11.46	0	0	11.2	0.1	1
2025	10	27	19	52	15	0	0	0	0	0	0	0	11.44	0	0	11.2	0.1	1
2025	10	27	20	2	15	0	0	0	0	0	0	0	11.41	0	0	11.2	0.1	1
2025	10	27	20	12	15	0	0	0	0	0	0	0	11.38	0	0	11.2	0.1	1
2025	10	27	20	22	15	0	0	0	0	0	0	0	11.35	0	0	11.2	0.1	1
2025	10	27	20	32	15	0	0	0	0	0	0	0	11.33	0	0	11.2	0.1	1
2025	10	27	20	42	15	0	0	0	0	0	0	0	11.31	0	0	11.2	0.1	1
2025	10	27	20	52	15	0	0	0	0	0	0	0	11.28	0	0	11.2	0.1	1
2025	10	27	21	2	15	0	0	0	0	0	0	0	11.25	0	0	11	0.1	1
2025	10	27	21	12	15	0	0	0	0	0	0	0	11.23	0	0	11	0.1	1
2025	10	27	21	22	15	0	0	0	0	0	0	0	11.2	0	0	11	0.1	1
2025	10	27	21	32	15	0	0	0	0	0	0	0	11.18	0	0	11	0.1	1
2025	10	27	21	42	15	0	0	0	0	0	0	0	11.15	0	0	11	0.1	1
2025	10	27	21	52	15	0	0	0	0	0	0	0	11.13	0	0	11	0.1	1
2025	10	27	22	2	15	0	0	0	0	0	0	0	11.1	0	0	11	0.1	1
2025	10	27	22	12	15	0	0	0	0	0	0	0	11.08	0	0	11	0.1	1
2025	10	27	22	22	15	0	0	0	0	0	0	0	11.06	0	0	11	0.1	1
2025	10	27	22	32	15	0	0	0	0	0	0	0	11.03	0	0	11	0.1	1
2025	10	27	22	42	15	0	0	0	0	0	0	0	11.01	0	0	11	0.1	1
2025	10	27	22	52	15	0	0	0	0	0	0	0	10.99	0	0	11	0.1	1
2025	10	27	23	2	15	0	0	0	0	0	0	0	10.97	0	0	11	0.1	1
2025	10	27	23	12	15	0	0	0	0	0	0	0	10.95	0	0	11	0.1	1
2025	10	27	23	22	15	0	0	0	0	0	0	0	10.93	0	0	11	0.1	1
2025	10	27	23	32	15	0	0	0	0	0	0	0	10.91	0	0	11	0.1	1
2025	10	27	23	42	15	0	0	0	0	0	0	0	10.89	0	0	11	0.1	1
2025	10	27	23	52	15	0	0	0	0	0	0	0	10.88	0	0	11	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	28	0	2	15	0	0	0	0	0	0	0	10.86	0	0	11	0.1	1
2025	10	28	0	12	15	0	0	0	0	0	0	0	10.84	0	0	11	0.1	1
2025	10	28	0	22	15	0	0	0	0	0	0	0	10.83	0	0	11	0.1	1
2025	10	28	0	32	15	0	0	0	0	0	0	0	10.82	0	0	11	0.1	1
2025	10	28	0	42	15	0	0	0	0	0	0	0	10.8	0	0	11	0.1	1
2025	10	28	0	52	15	0	0	0	0	0	0	0	10.79	0	0	11	0.1	1
2025	10	28	1	2	15	0	0	0	0	0	0	0	10.78	0	0	11	0.1	1
2025	10	28	1	12	15	0	0	0	0	0	0	0	10.77	0	0	11	0.1	1
2025	10	28	1	22	15	0	0	0	0	0	0	0	10.76	0	0	11	0.1	1
2025	10	28	1	32	15	0	0	0	0	0	0	0	10.75	0	0	11	0.1	1
2025	10	28	1	42	15	0	0	0	0	0	0	0	10.74	0	0	11	0.1	1
2025	10	28	1	52	15	0	0	0	0	0	0	0	10.74	0	0	11	0.1	1
2025	10	28	2	2	15	0	0	0	0	0	0	0	10.73	0	0	11	0.1	1
2025	10	28	2	12	15	0	0	0	0	0	0	0	10.73	0	0	11	0.1	1
2025	10	28	2	22	15	0	0	0	0	0	0	0	10.72	0	0	11	0.1	1
2025	10	28	2	32	15	0	0	0	0	0	0	0	10.71	0	0	11	0.1	1
2025	10	28	2	42	15	0	0	0	0	0	0	0	10.71	0	0	11	0.1	1
2025	10	28	2	52	15	0	0	0	0	0	0	0	10.71	0	0	11	0.1	1
2025	10	28	3	2	15	0	0	0	0	0	0	0	10.7	0	0	11	0.1	1
2025	10	28	3	12	15	0	0	0	0	0	0	0	10.7	0	0	11	0.1	1
2025	10	28	3	22	15	0	0	0	0	0	0	0	10.71	0	0	11	0.1	1
2025	10	28	3	32	15	0	0	0	0	0	0	0	10.71	0	0	11	0.1	1
2025	10	28	3	42	15	0	0	0	0	0	0	0	10.71	0	0	11	0.1	1
2025	10	28	3	52	15	0	0	0	0	0	0	0	10.71	0	0	11	0.1	1
2025	10	28	4	2	15	0	0	0	0	0	0	0	10.71	0	0	10.8	0.1	1
2025	10	28	4	12	15	0	0	0	0	0	0	0	10.71	0	0	10.8	0.1	1
2025	10	28	4	22	15	0	0	0	0	0	0	0	10.71	0	0	10.8	0.1	1
2025	10	28	4	32	15	0	0	0	0	0	0	0	10.71	0	0	10.8	0.1	1
2025	10	28	4	42	15	0	0	0	0	0	0	0	10.71	0	0	10.8	0.1	1
2025	10	28	4	52	15	0	0	0	0	0	0	0	10.71	0	0	10.8	0.1	1
2025	10	28	5	2	15	0	0	0	0	0	0	0	10.71	0	0	10.8	0.1	1
2025	10	28	5	12	15	0	0	0	0	0	0	0	10.72	0	0	10.8	0.1	1
2025	10	28	5	22	15	0	0	0	0	0	0	0	10.72	0	0	10.8	0.1	1
2025	10	28	5	32	15	0	0	0	0	0	0	0	10.72	0	0	10.8	0.1	1
2025	10	28	5	42	15	0	0	0	0	0	0	0	10.72	0	0	10.8	0.1	1
2025	10	28	5	52	15	0	0	0	0	0	0	0	10.72	0	0	10.8	0.1	1
2025	10	28	6	2	15	0	0	0	0	0	0	0	10.73	0	0	10.8	0.1	1
2025	10	28	6	12	15	0	0	0	0	0	0	0	10.73	0	0	10.8	0.1	1
2025	10	28	6	22	15	0	0	0	0	0	0	0	10.73	0	0	10.8	0.1	1
2025	10	28	6	32	15	0	0	0	0	0	0	0	10.73	0	0	10.8	0.1	1
2025	10	28	6	42	15	0	0	0	0	0	0	0	10.74	0	0	10.8	0.1	1
2025	10	28	6	52	15	0	0	0	0	0	0	0	10.73	0	0	10.8	0.1	1
2025	10	28	7	2	15	0	0	0	0	0	0	0	10.74	0	0	10.8	0.1	1
2025	10	28	7	12	15	0	0	0	0	0	0	0	10.74	0	0	10.8	0.1	1
2025	10	28	7	22	15	0	0	0	0	0	0	0	10.74	0	0	11	0.1	1
2025	10	28	7	32	15	0	0	0	0	0	0	0	10.74	0	0	11	0.1	1
2025	10	28	7	42	15	0	0	0	0	0	0	0	10.74	0	0	11	0.1	1
2025	10	28	7	52	15	0	0	0	0	0	0	0	10.74	0	0	11.2	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	28	8	2	15	0	0	0	0	0	0	0	10.75	0	0	11.4	0.1	1
2025	10	28	8	12	15	0	0	0	0	0	0	0	10.76	0	0	11.8	0.1	1
2025	10	28	8	22	15	0	0	0	0	0	0	0	10.76	0	0	12.2	0.1	1
2025	10	28	8	32	15	0	0	0	0	0	0	0	10.77	0	0	12.4	0.1	1
2025	10	28	8	42	15	0	0	0	0	0	0	0	10.82	0	0	12.6	0.1	1
2025	10	28	8	52	15	0	0	0	0	0	0	0	10.85	0	0	12.6	0.1	1
2025	10	28	9	2	15	0	0	0	0	0	0	0	10.89	0	0	12.4	0.1	1
2025	10	28	9	12	15	0	0	0	0	0	0	0	10.92	0	0	12.4	0.1	1
2025	10	28	9	22	15	0	0	0	0	0	0	0	10.95	0	0	12.4	0.1	1
2025	10	28	9	32	15	0	0	0	0	0	0	0	10.98	0	0	12.4	0.1	1
2025	10	28	9	42	15	0	0	0	0	0	0	0	11.02	0	0	12.6	0.1	1
2025	10	28	9	52	15	0	0	0	0	0	0	0	11.04	0	0	12.6	0.1	1
2025	10	28	10	2	15	0	0	0	0	0	0	0	11.09	0	0	12.8	0.1	1
2025	10	28	10	12	15	0	0	0	0	0	0	0	11.12	0	0	13.2	0.1	1
2025	10	28	10	22	15	0	0	0	0	0	0	0	11.16	0	0	13.4	0.1	1
2025	10	28	10	32	15	0	0	0	0	0	0	0	11.18	0	0	13.8	0.1	1
2025	10	28	10	42	15	0	0	0	0	0	0	0	11.21	0	0	14	0.1	1
2025	10	28	10	52	15	0	0	0	0	0	0	0	11.24	0	0	14.2	0.1	1
2025	10	28	11	2	15	0	0	0	0	0	0	0	11.27	0	0	14.2	0.1	1
2025	10	28	11	12	15	0	0	0	0	0	0	0	11.29	0	0	14	0.1	1
2025	10	28	11	22	15	0	0	0	0	0	0	0	11.32	0	0	14.2	0.1	1
2025	10	28	11	32	15	0	0	0	0	0	0	0	11.34	0	0	13	0.1	1
2025	10	28	11	42	15	0	0	0	0	0	0	0	11.36	0	0	13.2	0.1	1
2025	10	28	11	52	15	0	0	0	0	0	0	0	11.4	0	0	13.2	0.1	1
2025	10	28	12	2	15	0	0	0	0	0	0	0	11.42	0	0	13	0.1	1
2025	10	28	12	12	15	0	0	0	0	0	0	0	11.43	0	0	13	0.1	1
2025	10	28	12	22	15	0	0	0	0	0	0	0	11.46	0	0	13	0.1	1
2025	10	28	12	32	15	0	0	0	0	0	0	0	11.46	0	0	13	0.1	1
2025	10	28	12	42	15	0	0	0	0	0	0	0	11.55	0	0	13.2	0.1	1
2025	10	28	12	52	15	0	0	0	0	0	0	0	11.56	0	0	13.2	0.1	1
2025	10	28	13	2	15	0	0	0	0	0	0	0	11.57	0	0	13.2	0.1	1
2025	10	28	13	12	15	0	0	0	0	0	0	0	11.58	0	0	13.2	0.1	1
2025	10	28	13	22	15	0	0	0	0	0	0	0	11.59	0	0	13.6	0.1	1
2025	10	28	13	32	15	0	0	0	0	0	0	0	11.6	0	0	13.6	0.1	1
2025	10	28	13	42	15	0	0	0	0	0	0	0	11.59	0	0	13.6	0.1	1
2025	10	28	13	52	15	0	0	0	0	0	0	0	11.59	0	0	13.6	0.1	1
2025	10	28	14	2	15	0	0	0	0	0	0	0	11.58	0	0	13.6	0.1	1
2025	10	28	14	12	15	0	0	0	0	0	0	0	11.58	0	0	13.6	0.1	1
2025	10	28	14	22	15	0	0	0	0	0	0	0	11.57	0	0	13.6	0.1	1
2025	10	28	14	32	15	0	0	0	0	0	0	0	11.56	0	0	13.4	0.1	1
2025	10	28	14	42	15	0	0	0	0	0	0	0	11.55	0	0	13.6	0.1	1
2025	10	28	14	52	15	0	0	0	0	0	0	0	11.53	0	0	13.6	0.1	1
2025	10	28	15	2	15	0	0	0	0	0	0	0	11.52	0	0	13.6	0.1	1
2025	10	28	15	12	15	0	0	0	0	0	0	0	11.51	0	0	13.6	0.1	1
2025	10	28	15	22	15	0	0	0	0	0	0	0	11.49	0	0	13.6	0.1	1
2025	10	28	15	32	15	0	0	0	0	0	0	0	11.47	0	0	13.6	0.1	1
2025	10	28	15	42	15	0	0	0	0	0	0	0	11.42	0	0	13.6	0.1	1
2025	10	28	15	52	15	0	0	0	0	0	0	0	11.37	0	0	13.6	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	28	16	2	15	0	0	0	0	0	0	0	11.36	0	0	13.6	0.1	1
2025	10	28	16	12	15	0	0	0	0	0	0	0	11.33	0	0	13.6	0.1	1
2025	10	28	16	22	15	0	0	0	0	0	0	0	11.31	0	0	12.8	0.1	1
2025	10	28	16	32	15	0	0	0	0	0	0	0	11.3	0	0	12.4	0.1	1
2025	10	28	16	42	15	0	0	0	0	0	0	0	11.29	0	0	12.4	0.1	1
2025	10	28	16	52	15	0	0	0	0	0	0	0	11.28	0	0	12.2	0.1	1
2025	10	28	17	2	15	0	0	0	0	0	0	0	11.28	0	0	12	0.1	1
2025	10	28	17	12	15	0	0	0	0	0	0	0	11.27	0	0	12	0.1	1
2025	10	28	17	22	15	0	0	0	0	0	0	0	11.26	0	0	11.8	0.1	1
2025	10	28	17	32	15	0	0	0	0	0	0	0	11.25	0	0	11.8	0.1	1
2025	10	28	17	42	15	0	0	0	0	0	0	0	11.23	0	0	11.8	0.1	1
2025	10	28	17	52	15	0	0	0	0	0	0	0	11.22	0	0	11.4	0.1	1
2025	10	28	18	2	15	0	0	0	0	0	0	0	11.2	0	0	11.4	0.1	1
2025	10	28	18	12	15	0	0	0	0	0	0	0	11.18	0	0	11.2	0.1	1
2025	10	28	18	22	15	0	0	0	0	0	0	0	11.17	0	0	11.2	0.1	1
2025	10	28	18	32	15	0	0	0	0	0	0	0	11.14	0	0	11.2	0.1	1
2025	10	28	18	42	15	0	0	0	0	0	0	0	11.12	0	0	11.2	0.1	1
2025	10	28	18	52	15	0	0	0	0	0	0	0	11.1	0	0	11.2	0.1	1
2025	10	28	19	2	15	0	0	0	0	0	0	0	11.08	0	0	11.2	0.1	1
2025	10	28	19	12	15	0	0	0	0	0	0	0	11.05	0	0	11.2	0.1	1
2025	10	28	19	22	15	0	0	0	0	0	0	0	11.03	0	0	11.2	0.1	1
2025	10	28	19	32	15	0	0	0	0	0	0	0	11	0	0	11.2	0.1	1
2025	10	28	19	42	15	0	0	0	0	0	0	0	10.97	0	0	11.2	0.1	1
2025	10	28	19	52	15	0	0	0	0	0	0	0	10.95	0	0	11.2	0.1	1
2025	10	28	20	2	15	0	0	0	0	0	0	0	10.92	0	0	11.2	0.1	1
2025	10	28	20	12	15	0	0	0	0	0	0	0	10.9	0	0	11	0.1	1
2025	10	28	20	22	15	0	0	0	0	0	0	0	10.87	0	0	11	0.1	1
2025	10	28	20	32	15	0	0	0	0	0	0	0	10.84	0	0	11	0.1	1
2025	10	28	20	42	15	0	0	0	0	0	0	0	10.82	0	0	11	0.1	1
2025	10	28	20	52	15	0	0	0	0	0	0	0	10.79	0	0	11	0.1	1
2025	10	28	21	2	15	0	0	0	0	0	0	0	10.76	0	0	11	0.1	1
2025	10	28	21	12	15	0	0	0	0	0	0	0	10.74	0	0	11	0.1	1
2025	10	28	21	22	15	0	0	0	0	0	0	0	10.71	0	0	11	0.1	1
2025	10	28	21	32	15	0	0	0	0	0	0	0	10.68	0	0	11	0.1	1
2025	10	28	21	42	15	0	0	0	0	0	0	0	10.66	0	0	11	0.1	1
2025	10	28	21	52	15	0	0	0	0	0	0	0	10.63	0	0	11	0.1	1
2025	10	28	22	2	15	0	0	0	0	0	0	0	10.61	0	0	11	0.1	1
2025	10	28	22	12	15	0	0	0	0	0	0	0	10.58	0	0	11	0.1	1
2025	10	28	22	22	15	0	0	0	0	0	0	0	10.55	0	0	11	0.1	1
2025	10	28	22	32	15	0	0	0	0	0	0	0	10.53	0	0	11	0.1	1
2025	10	28	22	42	15	0	0	0	0	0	0	0	10.51	0	0	11	0.1	1
2025	10	28	22	52	15	0	0	0	0	0	0	0	10.48	0	0	11	0.1	1
2025	10	28	23	2	15	0	0	0	0	0	0	0	10.46	0	0	11	0.1	1
2025	10	28	23	12	15	0	0	0	0	0	0	0	10.44	0	0	11	0.1	1
2025	10	28	23	22	15	0	0	0	0	0	0	0	10.42	0	0	11	0.1	1
2025	10	28	23	32	15	0	0	0	0	0	0	0	10.4	0	0	11	0.1	1
2025	10	28	23	42	15	0	0	0	0	0	0	0	10.38	0	0	11	0.1	1
2025	10	28	23	52	15	0	0	0	0	0	0	0	10.36	0	0	11	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	29	0	2	15	0	0	0	0	0	0	0	10.35	0	0	11	0.1	1
2025	10	29	0	12	15	0	0	0	0	0	0	0	10.34	0	0	11	0.1	1
2025	10	29	0	22	15	0	0	0	0	0	0	0	10.32	0	0	11	0.1	1
2025	10	29	0	32	15	0	0	0	0	0	0	0	10.31	0	0	11	0.1	1
2025	10	29	0	42	15	0	0	0	0	0	0	0	10.29	0	0	11	0.1	1
2025	10	29	0	52	15	0	0	0	0	0	0	0	10.28	0	0	11	0.1	1
2025	10	29	1	2	15	0	0	0	0	0	0	0	10.27	0	0	11	0.1	1
2025	10	29	1	12	15	0	0	0	0	0	0	0	10.26	0	0	11	0.1	1
2025	10	29	1	22	15	0	0	0	0	0	0	0	10.25	0	0	11	0.1	1
2025	10	29	1	32	15	0	0	0	0	0	0	0	10.24	0	0	11	0.1	1
2025	10	29	1	42	15	0	0	0	0	0	0	0	10.24	0	0	10.8	0.1	1
2025	10	29	1	52	15	0	0	0	0	0	0	0	10.23	0	0	10.8	0.1	1
2025	10	29	2	2	15	0	0	0	0	0	0	0	10.22	0	0	10.8	0.1	1
2025	10	29	2	12	15	0	0	0	0	0	0	0	10.22	0	0	11	0.1	1
2025	10	29	2	22	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	2	32	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	2	42	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	2	52	15	0	0	0	0	0	0	0	10.21	0	0	11.2	0.1	1
2025	10	29	3	2	15	0	0	0	0	0	0	0	10.21	0	0	11.2	0.1	1
2025	10	29	3	12	15	0	0	0	0	0	0	0	10.21	0	0	11.2	0.1	1
2025	10	29	3	22	15	0	0	0	0	0	0	0	10.21	0	0	11.2	0.1	1
2025	10	29	3	32	15	0	0	0	0	0	0	0	10.21	0	0	11.2	0.1	1
2025	10	29	3	42	15	0	0	0	0	0	0	0	10.21	0	0	11.2	0.1	1
2025	10	29	3	52	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	4	2	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	4	12	15	0	0	0	0	0	0	0	10.2	0	0	11	0.1	1
2025	10	29	4	22	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	4	32	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	4	42	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	4	52	15	0	0	0	0	0	0	0	10.2	0	0	11	0.1	1
2025	10	29	5	2	15	0	0	0	0	0	0	0	10.2	0	0	11	0.1	1
2025	10	29	5	12	15	0	0	0	0	0	0	0	10.2	0	0	11	0.1	1
2025	10	29	5	22	15	0	0	0	0	0	0	0	10.2	0	0	11	0.1	1
2025	10	29	5	32	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	5	42	15	0	0	0	0	0	0	0	10.2	0	0	11	0.1	1
2025	10	29	5	52	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	6	2	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	6	12	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	6	22	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	6	32	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	6	42	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	6	52	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	7	2	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	7	12	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	7	22	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	7	32	15	0	0	0	0	0	0	0	10.2	0	0	11	0.1	1
2025	10	29	7	42	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1
2025	10	29	7	52	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	29	8	2	15	0	0	0	0	0	0	0	10.21	0	0	11.4	0.1	1
2025	10	29	8	12	15	0	0	0	0	0	0	0	10.21	0	0	11.8	0.1	1
2025	10	29	8	22	15	0	0	0	0	0	0	0	10.22	0	0	12	0.1	1
2025	10	29	8	32	15	0	0	0	0	0	0	0	10.23	0	0	12.2	0.1	1
2025	10	29	8	42	15	0	0	0	0	0	0	0	10.27	0	0	12.6	0.1	1
2025	10	29	8	52	15	0	0	0	0	0	0	0	10.31	0	0	12.4	0.1	1
2025	10	29	9	2	15	0	0	0	0	0	0	0	10.35	0	0	12.4	0.1	1
2025	10	29	9	12	15	0	0	0	0	0	0	0	10.38	0	0	12.4	0.1	1
2025	10	29	9	22	15	0	0	0	0	0	0	0	10.41	0	0	12.4	0.1	1
2025	10	29	9	32	15	0	0	0	0	0	0	0	10.45	0	0	12.6	0.1	1
2025	10	29	9	42	15	0	0	0	0	0	0	0	10.49	0	0	12.6	0.1	1
2025	10	29	9	52	15	0	0	0	0	0	0	0	10.52	0	0	12.6	0.1	1
2025	10	29	10	2	15	0	0	0	0	0	0	0	10.55	0	0	12.8	0.1	1
2025	10	29	10	12	15	0	0	0	0	0	0	0	10.59	0	0	13.4	0.1	1
2025	10	29	10	22	15	0	0	0	0	0	0	0	10.64	0	0	13.4	0.1	1
2025	10	29	10	32	15	0	0	0	0	0	0	0	10.68	0	0	13.4	0.1	1
2025	10	29	10	42	15	0	0	0	0	0	0	0	10.72	0	0	13.4	0.1	1
2025	10	29	10	52	15	0	0	0	0	0	0	0	10.75	0	0	13.2	0.1	1
2025	10	29	11	2	15	0	0	0	0	0	0	0	10.79	0	0	13.2	0.1	1
2025	10	29	11	12	15	0	0	0	0	0	0	0	10.81	0	0	13	0.1	1
2025	10	29	11	22	15	0	0	0	0	0	0	0	10.86	0	0	12.8	0.1	1
2025	10	29	11	32	15	0	0	0	0	0	0	0	10.89	0	0	13	0.1	1
2025	10	29	11	42	15	0	0	0	0	0	0	0	10.92	0	0	13.2	0.1	1
2025	10	29	11	52	15	0	0	0	0	0	0	0	10.94	0	0	13.4	0.1	1
2025	10	29	12	2	15	0	0	0	0	0	0	0	10.97	0	0	13	0.1	1
2025	10	29	12	12	15	0	0	0	0	0	0	0	10.99	0	0	12.8	0.1	1
2025	10	29	12	22	15	0	0	0	0	0	0	0	11	0	0	12.8	0.1	1
2025	10	29	12	32	15	0	0	0	0	0	0	0	11.03	0	0	12.8	0.1	1
2025	10	29	12	42	15	0	0	0	0	0	0	0	11.04	0	0	13.2	0.1	1
2025	10	29	12	52	15	0	0	0	0	0	0	0	11.06	0	0	13.8	0.1	1
2025	10	29	13	2	15	0	0	0	0	0	0	0	11.07	0	0	13.8	0.1	1
2025	10	29	13	12	15	0	0	0	0	0	0	0	11.08	0	0	14	0.1	1
2025	10	29	13	22	15	0	0	0	0	0	0	0	11.09	0	0	14	0.1	1
2025	10	29	13	32	15	0	0	0	0	0	0	0	11.09	0	0	14	0.1	1
2025	10	29	13	42	15	0	0	0	0	0	0	0	11.09	0	0	14	0.1	1
2025	10	29	13	52	15	0	0	0	0	0	0	0	11.09	0	0	14	0.1	1
2025	10	29	14	2	15	0	0	0	0	0	0	0	11.09	0	0	13.8	0.1	1
2025	10	29	14	12	15	0	0	0	0	0	0	0	11.08	0	0	14	0.1	1
2025	10	29	14	22	15	0	0	0	0	0	0	0	11.08	0	0	13.8	0.1	1
2025	10	29	14	32	15	0	0	0	0	0	0	0	11.07	0	0	13.6	0.1	1
2025	10	29	14	42	15	0	0	0	0	0	0	0	11.06	0	0	13.6	0.1	1
2025	10	29	14	52	15	0	0	0	0	0	0	0	11.04	0	0	13.6	0.1	1
2025	10	29	15	2	15	0	0	0	0	0	0	0	11.03	0	0	13.6	0.1	1
2025	10	29	15	12	15	0	0	0	0	0	0	0	11	0	0	13.4	0.1	1
2025	10	29	15	22	15	0	0	0	0	0	0	0	11	0	0	13.2	0.1	1
2025	10	29	15	32	15	0	0	0	0	0	0	0	10.98	0	0	13	0.1	1
2025	10	29	15	42	15	0	0	0	0	0	0	0	10.91	0	0	13	0.1	1
2025	10	29	15	52	15	0	0	0	0	0	0	0	10.88	0	0	13	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	29	16	2	15	0	0	0	0	0	0	0	10.87	0	0	13	0.1	1
2025	10	29	16	12	15	0	0	0	0	0	0	0	10.84	0	0	13	0.1	1
2025	10	29	16	22	15	0	0	0	0	0	0	0	10.82	0	0	12.6	0.1	1
2025	10	29	16	32	15	0	0	0	0	0	0	0	10.81	0	0	12.2	0.1	1
2025	10	29	16	42	15	0	0	0	0	0	0	0	10.8	0	0	12.2	0.1	1
2025	10	29	16	52	15	0	0	0	0	0	0	0	10.8	0	0	12	0.1	1
2025	10	29	17	2	15	0	0	0	0	0	0	0	10.79	0	0	11.8	0.1	1
2025	10	29	17	12	15	0	0	0	0	0	0	0	10.78	0	0	11.6	0.1	1
2025	10	29	17	22	15	0	0	0	0	0	0	0	10.77	0	0	11.6	0.1	1
2025	10	29	17	32	15	0	0	0	0	0	0	0	10.76	0	0	11.8	0.1	1
2025	10	29	17	42	15	0	0	0	0	0	0	0	10.75	0	0	11.2	0.1	1
2025	10	29	17	52	15	0	0	0	0	0	0	0	10.73	0	0	11.6	0.1	1
2025	10	29	18	2	15	0	0	0	0	0	0	0	10.73	0	0	11.6	0.1	1
2025	10	29	18	12	15	0	0	0	0	0	0	0	10.71	0	0	11.6	0.1	1
2025	10	29	18	22	15	0	0	0	0	0	0	0	10.69	0	0	11.6	0.1	1
2025	10	29	18	32	15	0	0	0	0	0	0	0	10.68	0	0	11.6	0.1	1
2025	10	29	18	42	15	0	0	0	0	0	0	0	10.65	0	0	11.6	0.1	1
2025	10	29	18	52	15	0	0	0	0	0	0	0	10.63	0	0	11.6	0.1	1
2025	10	29	19	2	15	0	0	0	0	0	0	0	10.61	0	0	11.6	0.1	1
2025	10	29	19	12	15	0	0	0	0	0	0	0	10.59	0	0	11.6	0.1	1
2025	10	29	19	22	15	0	0	0	0	0	0	0	10.56	0	0	11.6	0.1	1
2025	10	29	19	32	15	0	0	0	0	0	0	0	10.54	0	0	11.6	0.1	1
2025	10	29	19	42	15	0	0	0	0	0	0	0	10.51	0	0	11.6	0.1	1
2025	10	29	19	52	15	0	0	0	0	0	0	0	10.48	0	0	11.6	0.1	1
2025	10	29	20	2	15	0	0	0	0	0	0	0	10.45	0	0	11.6	0.1	1
2025	10	29	20	12	15	0	0	0	0	0	0	0	10.43	0	0	11.6	0.1	1
2025	10	29	20	22	15	0	0	0	0	0	0	0	10.4	0	0	11.6	0.1	1
2025	10	29	20	32	15	0	0	0	0	0	0	0	10.38	0	0	11.6	0.1	1
2025	10	29	20	42	15	0	0	0	0	0	0	0	10.35	0	0	11.6	0.1	1
2025	10	29	20	52	15	0	0	0	0	0	0	0	10.33	0	0	11.6	0.1	1
2025	10	29	21	2	15	0	0	0	0	0	0	0	10.3	0	0	11.6	0.1	1
2025	10	29	21	12	15	0	0	0	0	0	0	0	10.27	0	0	11.6	0.1	1
2025	10	29	21	22	15	0	0	0	0	0	0	0	10.24	0	0	11.6	0.1	1
2025	10	29	21	32	15	0	0	0	0	0	0	0	10.22	0	0	11.6	0.1	1
2025	10	29	21	42	15	0	0	0	0	0	0	0	10.2	0	0	11.6	0.1	1
2025	10	29	21	52	15	0	0	0	0	0	0	0	10.18	0	0	11.6	0.1	1
2025	10	29	22	2	15	0	0	0	0	0	0	0	10.15	0	0	11.6	0.1	1
2025	10	29	22	12	15	0	0	0	0	0	0	0	10.13	0	0	11.6	0.1	1
2025	10	29	22	22	15	0	0	0	0	0	0	0	10.1	0	0	11.6	0.1	1
2025	10	29	22	32	15	0	0	0	0	0	0	0	10.09	0	0	11.6	0.1	1
2025	10	29	22	42	15	0	0	0	0	0	0	0	10.06	0	0	11.4	0.1	1
2025	10	29	22	52	15	0	0	0	0	0	0	0	10.04	0	0	11.4	0.1	1
2025	10	29	23	2	15	0	0	0	0	0	0	0	10.02	0	0	11.4	0.1	1
2025	10	29	23	12	15	0	0	0	0	0	0	0	10.01	0	0	11.4	0.1	1
2025	10	29	23	22	15	0	0	0	0	0	0	0	9.98	0	0	11.4	0.1	1
2025	10	29	23	32	15	0	0	0	0	0	0	0	9.96	0	0	11.4	0.1	1
2025	10	29	23	42	15	0	0	0	0	0	0	0	9.95	0	0	11.4	0.1	1
2025	10	29	23	52	15	0	0	0	0	0	0	0	9.93	0	0	11.4	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	30	0	2	15	0	0	0	0	0	0	0	9.91	0	0	11.4	0.1	1
2025	10	30	0	12	15	0	0	0	0	0	0	0	9.9	0	0	11.6	0.1	1
2025	10	30	0	22	15	0	0	0	0	0	0	0	9.88	0	0	11.6	0.1	1
2025	10	30	0	32	15	0	0	0	0	0	0	0	9.88	0	0	11.6	0.1	1
2025	10	30	0	42	15	0	0	0	0	0	0	0	9.86	0	0	11.6	0.1	1
2025	10	30	0	52	15	0	0	0	0	0	0	0	9.85	0	0	11.6	0.1	1
2025	10	30	1	2	15	0	0	0	0	0	0	0	9.84	0	0	11.6	0.1	1
2025	10	30	1	12	15	0	0	0	0	0	0	0	9.83	0	0	11.6	0.1	1
2025	10	30	1	22	15	0	0	0	0	0	0	0	9.82	0	0	11.6	0.1	1
2025	10	30	1	32	15	0	0	0	0	0	0	0	9.82	0	0	11.6	0.1	1
2025	10	30	1	42	15	0	0	0	0	0	0	0	9.81	0	0	11.6	0.1	1
2025	10	30	1	52	15	0	0	0	0	0	0	0	9.81	0	0	11.4	0.1	1
2025	10	30	2	2	15	0	0	0	0	0	0	0	9.81	0	0	11.4	0.1	1
2025	10	30	2	12	15	0	0	0	0	0	0	0	9.8	0	0	11.4	0.1	1
2025	10	30	2	22	15	0	0	0	0	0	0	0	9.8	0	0	11.4	0.1	1
2025	10	30	2	32	15	0	0	0	0	0	0	0	9.8	0	0	11.4	0.1	1
2025	10	30	2	42	15	0	0	0	0	0	0	0	9.8	0	0	11.4	0.1	1
2025	10	30	2	52	15	0	0	0	0	0	0	0	9.8	0	0	11.4	0.1	1
2025	10	30	3	2	15	0	0	0	0	0	0	0	9.8	0	0	11.4	0.1	1
2025	10	30	3	12	15	0	0	0	0	0	0	0	9.8	0	0	11.4	0.1	1
2025	10	30	3	22	15	0	0	0	0	0	0	0	9.8	0	0	11.4	0.1	1
2025	10	30	3	32	15	0	0	0	0	0	0	0	9.81	0	0	11.4	0.1	1
2025	10	30	3	42	15	0	0	0	0	0	0	0	9.81	0	0	11.4	0.1	1
2025	10	30	3	52	15	0	0	0	0	0	0	0	9.81	0	0	11.4	0.1	1
2025	10	30	4	2	15	0	0	0	0	0	0	0	9.81	0	0	11.4	0.1	1
2025	10	30	4	12	15	0	0	0	0	0	0	0	9.82	0	0	11.4	0.1	1
2025	10	30	4	22	15	0	0	0	0	0	0	0	9.82	0	0	11.4	0.1	1
2025	10	30	4	32	15	0	0	0	0	0	0	0	9.82	0	0	11.4	0.1	1
2025	10	30	4	42	15	0	0	0	0	0	0	0	9.82	0	0	11.4	0.1	1
2025	10	30	4	52	15	0	0	0	0	0	0	0	9.82	0	0	11.4	0.1	1
2025	10	30	5	2	15	0	0	0	0	0	0	0	9.82	0	0	11.4	0.1	1
2025	10	30	5	12	15	0	0	0	0	0	0	0	9.83	0	0	11.4	0.1	1
2025	10	30	5	22	15	0	0	0	0	0	0	0	9.83	0	0	11.4	0.1	1
2025	10	30	5	32	15	0	0	0	0	0	0	0	9.83	0	0	11.4	0.1	1
2025	10	30	5	42	15	0	0	0	0	0	0	0	9.84	0	0	11.4	0.1	1
2025	10	30	5	52	15	0	0	0	0	0	0	0	9.84	0	0	11.4	0.1	1
2025	10	30	6	2	15	0	0	0	0	0	0	0	9.84	0	0	11.4	0.1	1
2025	10	30	6	12	15	0	0	0	0	0	0	0	9.84	0	0	11.4	0.1	1
2025	10	30	6	22	15	0	0	0	0	0	0	0	9.85	0	0	11.4	0.1	1
2025	10	30	6	32	15	0	0	0	0	0	0	0	9.85	0	0	11.4	0.1	1
2025	10	30	6	42	15	0	0	0	0	0	0	0	9.85	0	0	11.4	0.1	1
2025	10	30	6	52	15	0	0	0	0	0	0	0	9.85	0	0	11.4	0.1	1
2025	10	30	7	2	15	0	0	0	0	0	0	0	9.85	0	0	11.4	0.1	1
2025	10	30	7	12	15	0	0	0	0	0	0	0	9.86	0	0	11.4	0.1	1
2025	10	30	7	22	15	0	0	0	0	0	0	0	9.86	0	0	11.4	0.1	1
2025	10	30	7	32	15	0	0	0	0	0	0	0	9.87	0	0	11.4	0.1	1
2025	10	30	7	42	15	0	0	0	0	0	0	0	9.88	0	0	11.4	0.1	1
2025	10	30	7	52	15	0	0	0	0	0	0	0	9.88	0	0	11.4	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	30	8	2	15	0	0	0	0	0	0	0	9.89	0	0	11.8	0.1	1
2025	10	30	8	12	15	0	0	0	0	0	0	0	9.9	0	0	12	0.1	1
2025	10	30	8	22	15	0	0	0	0	0	0	0	9.9	0	0	12.2	0.1	1
2025	10	30	8	32	15	0	0	0	0	0	0	0	9.92	0	0	12.4	0.1	1
2025	10	30	8	42	15	0	0	0	0	0	0	0	9.96	0	0	12.6	0.1	1
2025	10	30	8	52	15	0	0	0	0	0	0	0	10	0	0	12.6	0.1	1
2025	10	30	9	2	15	0	0	0	0	0	0	0	10.04	0	0	12.6	0.1	1
2025	10	30	9	12	15	0	0	0	0	0	0	0	10.08	0	0	12.6	0.1	1
2025	10	30	9	22	15	0	0	0	0	0	0	0	10.12	0	0	12.6	0.1	1
2025	10	30	9	32	15	0	0	0	0	0	0	0	10.15	0	0	12.6	0.1	1
2025	10	30	9	42	15	0	0	0	0	0	0	0	10.19	0	0	12.6	0.1	1
2025	10	30	9	52	15	0	0	0	0	0	0	0	10.23	0	0	13	0.1	1
2025	10	30	10	2	15	0	0	0	0	0	0	0	10.27	0	0	12.4	0.1	1
2025	10	30	10	12	15	0	0	0	0	0	0	0	10.3	0	0	12.6	0.1	1
2025	10	30	10	22	15	0	0	0	0	0	0	0	10.35	0	0	13.2	0.1	1
2025	10	30	10	32	15	0	0	0	0	0	0	0	10.38	0	0	13.2	0.1	1
2025	10	30	10	42	15	0	0	0	0	0	0	0	10.43	0	0	13	0.1	1
2025	10	30	10	52	15	0	0	0	0	0	0	0	10.46	0	0	13	0.1	1
2025	10	30	11	2	15	0	0	0	0	0	0	0	10.49	0	0	13	0.1	1
2025	10	30	11	12	15	0	0	0	0	0	0	0	10.52	0	0	13	0.1	1
2025	10	30	11	22	15	0	0	0	0	0	0	0	10.57	0	0	13	0.1	1
2025	10	30	11	32	15	0	0	0	0	0	0	0	10.59	0	0	13	0.1	1
2025	10	30	11	42	15	0	0	0	0	0	0	0	10.62	0	0	13	0.1	1
2025	10	30	11	52	15	0	0	0	0	0	0	0	10.65	0	0	13	0.1	1
2025	10	30	12	2	15	0	0	0	0	0	0	0	10.66	0	0	13	0.1	1
2025	10	30	12	12	15	0	0	0	0	0	0	0	10.69	0	0	13	0.1	1
2025	10	30	12	22	15	0	0	0	0	0	0	0	10.72	0	0	12.8	0.1	1
2025	10	30	12	32	15	0	0	0	0	0	0	0	10.72	0	0	12.6	0.1	1
2025	10	30	12	42	15	0	0	0	0	0	0	0	10.76	0	0	12.6	0.1	1
2025	10	30	12	52	15	0	0	0	0	0	0	0	10.76	0	0	12.6	0.1	1
2025	10	30	13	2	15	0	0	0	0	0	0	0	10.78	0	0	13	0.1	1
2025	10	30	13	12	15	0	0	0	0	0	0	0	10.79	0	0	13	0.1	1
2025	10	30	13	22	15	0	0	0	0	0	0	0	10.8	0	0	13	0.1	1
2025	10	30	13	32	15	0	0	0	0	0	0	0	10.8	0	0	13	0.1	1
2025	10	30	13	42	15	0	0	0	0	0	0	0	10.81	0	0	12.8	0.1	1
2025	10	30	13	52	15	0	0	0	0	0	0	0	10.82	0	0	12.8	0.1	1
2025	10	30	14	2	15	0	0	0	0	0	0	0	10.82	0	0	12.8	0.1	1
2025	10	30	14	12	15	0	0	0	0	0	0	0	10.82	0	0	12.8	0.1	1
2025	10	30	14	22	15	0	0	0	0	0	0	0	10.81	0	0	12.8	0.1	1
2025	10	30	14	32	15	0	0	0	0	0	0	0	10.82	0	0	13	0.1	1
2025	10	30	14	42	15	0	0	0	0	0	0	0	10.8	0	0	13	0.1	1
2025	10	30	14	52	15	0	0	0	0	0	0	0	10.8	0	0	13	0.1	1
2025	10	30	15	2	15	0	0	0	0	0	0	0	10.79	0	0	13	0.1	1
2025	10	30	15	12	15	0	0	0	0	0	0	0	10.78	0	0	13	0.1	1
2025	10	30	15	22	15	0	0	0	0	0	0	0	10.77	0	0	13	0.1	1
2025	10	30	15	32	15	0	0	0	0	0	0	0	10.75	0	0	13	0.1	1
2025	10	30	15	42	15	0	0	0	0	0	0	0	10.69	0	0	13	0.1	1
2025	10	30	15	52	15	0	0	0	0	0	0	0	10.67	0	0	13	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	30	16	2	15	0	0	0	0	0	0	0	10.65	0	0	13	0.1	1
2025	10	30	16	12	15	0	0	0	0	0	0	0	10.63	0	0	13	0.1	1
2025	10	30	16	22	15	0	0	0	0	0	0	0	10.61	0	0	12.4	0.1	1
2025	10	30	16	32	15	0	0	0	0	0	0	0	10.61	0	0	11.8	0.1	1
2025	10	30	16	42	15	0	0	0	0	0	0	0	10.6	0	0	11.8	0.1	1
2025	10	30	16	52	15	0	0	0	0	0	0	0	10.6	0	0	11.6	0.1	1
2025	10	30	17	2	15	0	0	0	0	0	0	0	10.59	0	0	11.4	0.1	1
2025	10	30	17	12	15	0	0	0	0	0	0	0	10.59	0	0	11.2	0.1	1
2025	10	30	17	22	15	0	0	0	0	0	0	0	10.58	0	0	11.2	0.1	1
2025	10	30	17	32	15	0	0	0	0	0	0	0	10.57	0	0	11.2	0.1	1
2025	10	30	17	42	15	0	0	0	0	0	0	0	10.56	0	0	11	0.1	1
2025	10	30	17	52	15	0	0	0	0	0	0	0	10.54	0	0	11	0.1	1
2025	10	30	18	2	15	0	0	0	0	0	0	0	10.53	0	0	11	0.1	1
2025	10	30	18	12	15	0	0	0	0	0	0	0	10.52	0	0	11	0.1	1
2025	10	30	18	22	15	0	0	0	0	0	0	0	10.5	0	0	11	0.1	1
2025	10	30	18	32	15	0	0	0	0	0	0	0	10.48	0	0	11	0.1	1
2025	10	30	18	42	15	0	0	0	0	0	0	0	10.46	0	0	11	0.1	1
2025	10	30	18	52	15	0	0	0	0	0	0	0	10.45	0	0	11	0.1	1
2025	10	30	19	2	15	0	0	0	0	0	0	0	10.42	0	0	11	0.1	1
2025	10	30	19	12	15	0	0	0	0	0	0	0	10.4	0	0	11	0.1	1
2025	10	30	19	22	15	0	0	0	0	0	0	0	10.38	0	0	11	0.1	1
2025	10	30	19	32	15	0	0	0	0	0	0	0	10.36	0	0	11	0.1	1
2025	10	30	19	42	15	0	0	0	0	0	0	0	10.33	0	0	11	0.1	1
2025	10	30	19	52	15	0	0	0	0	0	0	0	10.3	0	0	11.6	0.1	1
2025	10	30	20	2	15	0	0	0	0	0	0	0	10.28	0	0	11.6	0.1	1
2025	10	30	20	12	15	0	0	0	0	0	0	0	10.25	0	0	11.6	0.1	1
2025	10	30	20	22	15	0	0	0	0	0	0	0	10.23	0	0	11.6	0.1	1
2025	10	30	20	32	15	0	0	0	0	0	0	0	10.21	0	0	11.6	0.1	1
2025	10	30	20	42	15	0	0	0	0	0	0	0	10.19	0	0	11.6	0.1	1
2025	10	30	20	52	15	0	0	0	0	0	0	0	10.16	0	0	11.6	0.1	1
2025	10	30	21	2	15	0	0	0	0	0	0	0	10.14	0	0	11.6	0.1	1
2025	10	30	21	12	15	0	0	0	0	0	0	0	10.12	0	0	11.6	0.1	1
2025	10	30	21	22	15	0	0	0	0	0	0	0	10.09	0	0	11.6	0.1	1
2025	10	30	21	32	15	0	0	0	0	0	0	0	10.07	0	0	11.6	0.1	1
2025	10	30	21	42	15	0	0	0	0	0	0	0	10.04	0	0	11.6	0.1	1
2025	10	30	21	52	15	0	0	0	0	0	0	0	10.02	0	0	11.6	0.1	1
2025	10	30	22	2	15	0	0	0	0	0	0	0	10	0	0	11.6	0.1	1
2025	10	30	22	12	15	0	0	0	0	0	0	0	9.97	0	0	11.6	0.1	1
2025	10	30	22	22	15	0	0	0	0	0	0	0	9.95	0	0	10.8	0.1	1
2025	10	30	22	32	15	0	0	0	0	0	0	0	9.93	0	0	10.8	0.1	1
2025	10	30	22	42	15	0	0	0	0	0	0	0	9.91	0	0	10.8	0.1	1
2025	10	30	22	52	15	0	0	0	0	0	0	0	9.88	0	0	10.8	0.1	1
2025	10	30	23	2	15	0	0	0	0	0	0	0	9.87	0	0	10.8	0.1	1
2025	10	30	23	12	15	0	0	0	0	0	0	0	9.84	0	0	10.8	0.1	1
2025	10	30	23	22	15	0	0	0	0	0	0	0	9.83	0	0	10.8	0.1	1
2025	10	30	23	32	15	0	0	0	0	0	0	0	9.81	0	0	11.2	0.1	1
2025	10	30	23	42	15	0	0	0	0	0	0	0	9.8	0	0	11.2	0.1	1
2025	10	30	23	52	15	0	0	0	0	0	0	0	9.79	0	0	11.2	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	31	0	2	15	0	0	0	0	0	0	0	9.78	0	0	11	0.1	1
2025	10	31	0	12	15	0	0	0	0	0	0	0	9.76	0	0	11	0.1	1
2025	10	31	0	22	15	0	0	0	0	0	0	0	9.75	0	0	11	0.1	1
2025	10	31	0	32	15	0	0	0	0	0	0	0	9.74	0	0	11	0.1	1
2025	10	31	0	42	15	0	0	0	0	0	0	0	9.73	0	0	11	0.1	1
2025	10	31	0	52	15	0	0	0	0	0	0	0	9.72	0	0	11	0.1	1
2025	10	31	1	2	15	0	0	0	0	0	0	0	9.71	0	0	11	0.1	1
2025	10	31	1	12	15	0	0	0	0	0	0	0	9.71	0	0	11	0.1	1
2025	10	31	1	22	15	0	0	0	0	0	0	0	9.7	0	0	11	0.1	1
2025	10	31	1	32	15	0	0	0	0	0	0	0	9.7	0	0	10.8	0.1	1
2025	10	31	1	42	15	0	0	0	0	0	0	0	9.69	0	0	10.8	0.1	1
2025	10	31	1	52	15	0	0	0	0	0	0	0	9.69	0	0	10.8	0.1	1
2025	10	31	2	2	15	0	0	0	0	0	0	0	9.69	0	0	10.8	0.1	1
2025	10	31	2	12	15	0	0	0	0	0	0	0	9.69	0	0	10.8	0.1	1
2025	10	31	2	22	15	0	0	0	0	0	0	0	9.69	0	0	10.8	0.1	1
2025	10	31	2	32	15	0	0	0	0	0	0	0	9.69	0	0	10.8	0.1	1
2025	10	31	2	42	15	0	0	0	0	0	0	0	9.69	0	0	10.8	0.1	1
2025	10	31	2	52	15	0	0	0	0	0	0	0	9.69	0	0	10.8	0.1	1
2025	10	31	3	2	15	0	0	0	0	0	0	0	9.69	0	0	11.2	0.1	1
2025	10	31	3	12	15	0	0	0	0	0	0	0	9.69	0	0	11.4	0.1	1
2025	10	31	3	22	15	0	0	0	0	0	0	0	9.69	0	0	11.4	0.1	1
2025	10	31	3	32	15	0	0	0	0	0	0	0	9.69	0	0	11.4	0.1	1
2025	10	31	3	42	15	0	0	0	0	0	0	0	9.69	0	0	11.4	0.1	1
2025	10	31	3	52	15	0	0	0	0	0	0	0	9.7	0	0	11.4	0.1	1
2025	10	31	4	2	15	0	0	0	0	0	0	0	9.7	0	0	11.4	0.1	1
2025	10	31	4	12	15	0	0	0	0	0	0	0	9.71	0	0	11.4	0.1	1
2025	10	31	4	22	15	0	0	0	0	0	0	0	9.71	0	0	11.4	0.1	1
2025	10	31	4	32	15	0	0	0	0	0	0	0	9.71	0	0	11.4	0.1	1
2025	10	31	4	42	15	0	0	0	0	0	0	0	9.72	0	0	11.4	0.1	1
2025	10	31	4	52	15	0	0	0	0	0	0	0	9.73	0	0	11.4	0.1	1
2025	10	31	5	2	15	0	0	0	0	0	0	0	9.73	0	0	11.4	0.1	1
2025	10	31	5	12	15	0	0	0	0	0	0	0	9.73	0	0	11.4	0.1	1
2025	10	31	5	22	15	0	0	0	0	0	0	0	9.73	0	0	11.4	0.1	1
2025	10	31	5	32	15	0	0	0	0	0	0	0	9.74	0	0	11.4	0.1	1
2025	10	31	5	42	15	0	0	0	0	0	0	0	9.74	0	0	11.4	0.1	1
2025	10	31	5	52	15	0	0	0	0	0	0	0	9.75	0	0	11.4	0.1	1
2025	10	31	6	2	15	0	0	0	0	0	0	0	9.75	0	0	11.4	0.1	1
2025	10	31	6	12	15	0	0	0	0	0	0	0	9.76	0	0	11.4	0.1	1
2025	10	31	6	22	15	0	0	0	0	0	0	0	9.76	0	0	11.4	0.1	1
2025	10	31	6	32	15	0	0	0	0	0	0	0	9.77	0	0	11.4	0.1	1
2025	10	31	6	42	15	0	0	0	0	0	0	0	9.77	0	0	11.4	0.1	1
2025	10	31	6	52	15	0	0	0	0	0	0	0	9.77	0	0	11.4	0.1	1
2025	10	31	7	2	15	0	0	0	0	0	0	0	9.78	0	0	11.4	0.1	1
2025	10	31	7	12	15	0	0	0	0	0	0	0	9.78	0	0	11.4	0.1	1
2025	10	31	7	22	15	0	0	0	0	0	0	0	9.79	0	0	11.4	0.1	1
2025	10	31	7	32	15	0	0	0	0	0	0	0	9.79	0	0	11.4	0.1	1
2025	10	31	7	42	15	0	0	0	0	0	0	0	9.8	0	0	11.4	0.1	1
2025	10	31	7	52	15	0	0	0	0	0	0	0	9.8	0	0	11.4	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	31	8	2	15	0	0	0	0	0	0	0	9.81	0	0	11.8	0.1	1
2025	10	31	8	12	15	0	0	0	0	0	0	0	9.82	0	0	12	0.1	1
2025	10	31	8	22	15	0	0	0	0	0	0	0	9.83	0	0	12.2	0.1	1
2025	10	31	8	32	15	0	0	0	0	0	0	0	9.85	0	0	12.4	0.1	1
2025	10	31	8	42	15	0	0	0	0	0	0	0	9.87	0	0	12.4	0.1	1
2025	10	31	8	52	15	0	0	0	0	0	0	0	9.92	0	0	12	0.1	1
2025	10	31	9	2	15	0	0	0	0	0	0	0	9.95	0	0	12	0.1	1
2025	10	31	9	12	15	0	0	0	0	0	0	0	10	0	0	12	0.1	1
2025	10	31	9	22	15	0	0	0	0	0	0	0	10.03	0	0	12.2	0.1	1
2025	10	31	9	32	15	0	0	0	0	0	0	0	10.07	0	0	12.2	0.1	1
2025	10	31	9	42	15	0	0	0	0	0	0	0	10.11	0	0	12.2	0.1	1
2025	10	31	9	52	15	0	0	0	0	0	0	0	10.15	0	0	12.2	0.1	1
2025	10	31	10	2	15	0	0	0	0	0	0	0	10.18	0	0	12.2	0.1	1
2025	10	31	10	12	15	0	0	0	0	0	0	0	10.2	0	0	12.8	0.1	1
2025	10	31	10	22	15	0	0	0	0	0	0	0	10.24	0	0	13.4	0.1	1
2025	10	31	10	32	15	0	0	0	0	0	0	0	10.28	0	0	13.6	0.1	1
2025	10	31	10	42	15	0	0	0	0	0	0	0	10.3	0	0	13.6	0.1	1
2025	10	31	10	52	15	0	0	0	0	0	0	0	10.34	0	0	13.6	0.1	1
2025	10	31	11	2	15	0	0	0	0	0	0	0	10.39	0	0	13.6	0.1	1
2025	10	31	11	12	15	0	0	0	0	0	0	0	10.42	0	0	13.6	0.1	1
2025	10	31	11	22	15	0	0	0	0	0	0	0	10.46	0	0	13.6	0.1	1
2025	10	31	11	32	15	0	0	0	0	0	0	0	10.48	0	0	13.6	0.1	1
2025	10	31	11	42	15	0	0	0	0	0	0	0	10.51	0	0	13.6	0.1	1
2025	10	31	11	52	15	0	0	0	0	0	0	0	10.53	0	0	13.6	0.1	1
2025	10	31	12	2	15	0	0	0	0	0	0	0	10.56	0	0	13.6	0.1	1
2025	10	31	12	12	15	0	0	0	0	0	0	0	10.59	0	0	13.6	0.1	1
2025	10	31	12	22	15	0	0	0	0	0	0	0	10.61	0	0	13.4	0.1	1
2025	10	31	12	32	15	0	0	0	0	0	0	0	10.64	0	0	13.4	0.1	1
2025	10	31	12	42	15	0	0	0	0	0	0	0	10.65	0	0	13.4	0.1	1
2025	10	31	12	52	15	0	0	0	0	0	0	0	10.66	0	0	13.4	0.1	1
2025	10	31	13	2	15	0	0	0	0	0	0	0	10.67	0	0	13.4	0.1	1
2025	10	31	13	12	15	0	0	0	0	0	0	0	10.68	0	0	13.4	0.1	1
2025	10	31	13	22	15	0	0	0	0	0	0	0	10.69	0	0	13.4	0.1	1
2025	10	31	13	32	15	0	0	0	0	0	0	0	10.7	0	0	13.4	0.1	1
2025	10	31	13	42	15	0	0	0	0	0	0	0	10.7	0	0	13.4	0.1	1
2025	10	31	13	52	15	0	0	0	0	0	0	0	10.7	0	0	13.4	0.1	1
2025	10	31	14	2	15	0	0	0	0	0	0	0	10.71	0	0	13.4	0.1	1
2025	10	31	14	12	15	0	0	0	0	0	0	0	10.71	0	0	13.4	0.1	1
2025	10	31	14	22	15	0	0	0	0	0	0	0	10.71	0	0	13.4	0.1	1
2025	10	31	14	32	15	0	0	0	0	0	0	0	10.7	0	0	13.2	0.1	1
2025	10	31	14	42	15	0	0	0	0	0	0	0	10.69	0	0	13	0.1	1
2025	10	31	14	52	15	0	0	0	0	0	0	0	10.69	0	0	13.2	0.1	1
2025	10	31	15	2	15	0	0	0	0	0	0	0	10.68	0	0	13.2	0.1	1
2025	10	31	15	12	15	0	0	0	0	0	0	0	10.66	0	0	13.2	0.1	1
2025	10	31	15	22	15	0	0	0	0	0	0	0	10.65	0	0	12.8	0.1	1
2025	10	31	15	32	15	0	0	0	0	0	0	0	10.64	0	0	12.8	0.1	1
2025	10	31	15	42	15	0	0	0	0	0	0	0	10.57	0	0	12.8	0.1	1
2025	10	31	15	52	15	0	0	0	0	0	0	0	10.56	0	0	12.8	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	10	31	16	2	15	0	0	0	0	0	0	0	10.54	0	0	12.8	0.1	1
2025	10	31	16	12	15	0	0	0	0	0	0	0	10.53	0	0	12.8	0.1	1
2025	10	31	16	22	15	0	0	0	0	0	0	0	10.51	0	0	12.2	0.1	1
2025	10	31	16	32	15	0	0	0	0	0	0	0	10.5	0	0	12	0.1	1
2025	10	31	16	42	15	0	0	0	0	0	0	0	10.5	0	0	11.8	0.1	1
2025	10	31	16	52	15	0	0	0	0	0	0	0	10.5	0	0	11.6	0.1	1
2025	10	31	17	2	15	0	0	0	0	0	0	0	10.48	0	0	11.4	0.1	1
2025	10	31	17	12	15	0	0	0	0	0	0	0	10.48	0	0	11.2	0.1	1
2025	10	31	17	22	15	0	0	0	0	0	0	0	10.47	0	0	11.2	0.1	1
2025	10	31	17	32	15	0	0	0	0	0	0	0	10.46	0	0	11.2	0.1	1
2025	10	31	17	42	15	0	0	0	0	0	0	0	10.45	0	0	11.2	0.1	1
2025	10	31	17	52	15	0	0	0	0	0	0	0	10.44	0	0	11	0.1	1
2025	10	31	18	2	15	0	0	0	0	0	0	0	10.43	0	0	11	0.1	1
2025	10	31	18	12	15	0	0	0	0	0	0	0	10.41	0	0	11	0.1	1
2025	10	31	18	22	15	0	0	0	0	0	0	0	10.4	0	0	11	0.1	1
2025	10	31	18	32	15	0	0	0	0	0	0	0	10.38	0	0	11	0.1	1
2025	10	31	18	42	15	0	0	0	0	0	0	0	10.36	0	0	11	0.1	1
2025	10	31	18	52	15	0	0	0	0	0	0	0	10.34	0	0	11	0.1	1
2025	10	31	19	2	15	0	0	0	0	0	0	0	10.32	0	0	11	0.1	1
2025	10	31	19	12	15	0	0	0	0	0	0	0	10.3	0	0	11.4	0.1	1
2025	10	31	19	22	15	0	0	0	0	0	0	0	10.28	0	0	11.6	0.1	1
2025	10	31	19	32	15	0	0	0	0	0	0	0	10.26	0	0	11.6	0.1	1
2025	10	31	19	42	15	0	0	0	0	0	0	0	10.23	0	0	11.6	0.1	1
2025	10	31	19	52	15	0	0	0	0	0	0	0	10.21	0	0	11.6	0.1	1
2025	10	31	20	2	15	0	0	0	0	0	0	0	10.19	0	0	11.6	0.1	1
2025	10	31	20	12	15	0	0	0	0	0	0	0	10.16	0	0	11.6	0.1	1
2025	10	31	20	22	15	0	0	0	0	0	0	0	10.14	0	0	11.6	0.1	1
2025	10	31	20	32	15	0	0	0	0	0	0	0	10.12	0	0	11.6	0.1	1
2025	10	31	20	42	15	0	0	0	0	0	0	0	10.09	0	0	11.6	0.1	1
2025	10	31	20	52	15	0	0	0	0	0	0	0	10.07	0	0	11.6	0.1	1
2025	10	31	21	2	15	0	0	0	0	0	0	0	10.04	0	0	11.6	0.1	1
2025	10	31	21	12	15	0	0	0	0	0	0	0	10.02	0	0	11.6	0.1	1
2025	10	31	21	22	15	0	0	0	0	0	0	0	10	0	0	11.6	0.1	1
2025	10	31	21	32	15	0	0	0	0	0	0	0	9.97	0	0	11.6	0.1	1
2025	10	31	21	42	15	0	0	0	0	0	0	0	9.95	0	0	11.6	0.1	1
2025	10	31	21	52	15	0	0	0	0	0	0	0	9.93	0	0	11.6	0.1	1
2025	10	31	22	2	15	0	0	0	0	0	0	0	9.9	0	0	11.6	0.1	1
2025	10	31	22	12	15	0	0	0	0	0	0	0	9.88	0	0	11.6	0.1	1
2025	10	31	22	22	15	0	0	0	0	0	0	0	9.86	0	0	11.6	0.1	1
2025	10	31	22	32	15	0	0	0	0	0	0	0	9.84	0	0	11.6	0.1	1
2025	10	31	22	42	15	0	0	0	0	0	0	0	9.81	0	0	11.6	0.1	1
2025	10	31	22	52	15	0	0	0	0	0	0	0	9.8	0	0	11.6	0.1	1
2025	10	31	23	2	15	0	0	0	0	0	0	0	9.78	0	0	11.6	0.1	1
2025	10	31	23	12	15	0	0	0	0	0	0	0	9.76	0	0	11.6	0.1	1
2025	10	31	23	22	15	0	0	0	0	0	0	0	9.74	0	0	11.6	0.1	1
2025	10	31	23	32	15	0	0	0	0	0	0	0	9.72	0	0	11.6	0.1	1
2025	10	31	23	42	15	0	0	0	0	0	0	0	9.71	0	0	11.6	0.1	1
2025	10	31	23	52	15	0	0	0	0	0	0	0	9.69	0	0	11.6	0.1	1

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	1	0	0	30	29.19	94.5	7.7078	75.3166
2025	10	1	0	10	30	29.88	96.3	7.7078	76.8695
2025	10	1	0	20	30	29.06	93.6	7.7078	75.0578
2025	10	1	0	30	30	29.52	97	7.7078	75.8343
2025	10	1	0	40	30	28.15	93.5	7.7078	72.7284
2025	10	1	0	50	30	28.89	94.6	7.7078	74.5402
2025	10	1	1	0	30	29.22	95.1	7.7078	75.3166
2025	10	1	1	10	30	29.17	96.1	7.7078	75.0578
2025	10	1	1	20	30	28.82	92.2	7.7078	74.5402
2025	10	1	1	30	30	30.36	95.9	7.7078	78.1637
2025	10	1	1	40	30	30.11	95	7.7078	77.646
2025	10	1	1	50	30	29.01	94.9	7.7078	74.799
2025	10	1	2	0	30	28.9	94.8	7.7078	74.5402
2025	10	1	2	10	30	29.18	94.1	7.7078	75.3167
2025	10	1	2	20	30	28.91	97	7.7078	74.2814
2025	10	1	2	30	30	28.9	94.8	7.7078	74.5402
2025	10	1	2	40	30	28.79	94.6	7.7078	74.2814
2025	10	1	2	50	30	28.49	94.4	7.7078	73.5049
2025	10	1	3	0	30	29.94	97.3	7.7078	76.8696
2025	10	1	3	10	30	29.08	94.1	7.7078	75.0579
2025	10	1	3	20	30	28.97	94	7.7078	74.7991
2025	10	1	3	30	30	30.58	94.1	7.7078	78.9402
2025	10	1	3	40	30	29.77	93.9	7.7078	76.8696
2025	10	1	3	50	30	29.1	94.7	7.7078	75.0579
2025	10	1	4	0	30	28.11	91.4	7.7139	72.7886
2025	10	1	4	10	30	28.21	96.9	7.7078	72.4697
2025	10	1	4	20	30	29.86	93.6	7.7078	77.1285
2025	10	1	4	30	30	28.63	92.6	7.7078	74.0227
2025	10	1	4	40	30	30.16	95.9	7.7078	77.6462
2025	10	1	4	50	30	28.45	95.9	7.7078	73.2462
2025	10	1	5	0	30	29.58	94.3	7.7078	76.3521
2025	10	1	5	10	30	28.46	93.6	7.7139	73.5658
2025	10	1	5	20	30	28.96	93.6	7.7139	74.861
2025	10	1	5	30	30	29.72	95.2	7.7139	76.6742
2025	10	1	5	40	30	29.11	94.9	7.7139	75.12
2025	10	1	5	50	30	28.79	94.6	7.7139	74.3429
2025	10	1	6	0	30	28.83	97.2	7.7139	74.0839
2025	10	1	6	10	30	29.72	95.2	7.7139	76.6743
2025	10	1	6	20	30	28.65	93.4	7.7078	74.0228
2025	10	1	6	30	30	28.59	94.6	7.7078	73.764
2025	10	1	6	40	30	28.42	95.2	7.7139	73.3069
2025	10	1	6	50	30	28.46	93.6	7.7139	73.5659
2025	10	1	7	0	30	29.53	97.2	7.7139	75.8972
2025	10	1	7	10	30	29.42	95.3	7.7139	75.8973
2025	10	1	7	20	30	29.22	95.3	7.7139	75.3792
2025	10	1	7	30	30	29.61	94.8	7.7139	76.4154
2025	10	1	7	40	30	29.08	96.3	7.7139	74.8612
2025	10	1	7	50	30	29.25	93.3	7.7139	75.6383

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	1	8	0	30	29.24	95.7	7.7139	75.3793
2025	10	1	8	10	30	28.16	93.9	7.7139	72.7889
2025	10	1	8	20	30	29.16	93.7	7.7139	75.3793
2025	10	1	8	30	30	28.14	93.1	7.7139	72.7889
2025	10	1	8	40	30	29.55	93.5	7.7139	76.4154
2025	10	1	8	50	30	28.24	95.7	7.7139	72.7889
2025	10	1	9	0	30	29.42	95.3	7.7139	75.8973
2025	10	1	9	10	30	29.49	94.5	7.7139	76.1563
2025	10	1	9	20	30	29.46	93.7	7.7139	76.1563
2025	10	1	9	30	30	29.53	92.5	7.7139	76.4153
2025	10	1	9	40	30	28.86	93.8	7.7139	74.6021
2025	10	1	9	50	30	29.58	94.3	7.7139	76.4153
2025	10	1	10	0	30	28.45	93.4	7.7139	73.5659
2025	10	1	10	10	30	28.51	95	7.7139	73.5659
2025	10	1	10	20	30	28.88	94.2	7.7139	74.602
2025	10	1	10	30	30	29.32	95.3	7.72	75.7005
2025	10	1	10	40	30	28.91	97	7.72	74.4043
2025	10	1	10	50	30	28.57	96.2	7.72	73.6265
2025	10	1	11	0	30	28.18	96.5	7.72	72.5895
2025	10	1	11	10	30	29.67	96.2	7.72	76.4782
2025	10	1	11	20	30	28.35	95.9	7.7139	73.0477
2025	10	1	11	30	30	28.99	94.6	7.7139	74.8609
2025	10	1	11	40	30	30.56	95.8	7.7139	78.7464
2025	10	1	11	50	30	28.79	94.6	7.7139	74.3428
2025	10	1	12	0	30	29.31	96.9	7.72	75.4411
2025	10	1	12	10	30	29.22	95.3	7.7139	75.3789
2025	10	1	12	20	30	28.37	96.3	7.7139	73.0475
2025	10	1	12	30	30	28.8	94.8	7.7139	74.3427
2025	10	1	12	40	30	29.92	95.2	7.7139	77.1921
2025	10	1	12	50	30	27.89	94.5	7.7139	72.0114
2025	10	1	13	0	30	29.86	96	7.7139	76.933
2025	10	1	13	10	30	28.51	95	7.7139	73.5655
2025	10	1	13	20	30	28.79	94.6	7.7078	74.2813
2025	10	1	13	30	30	29.1	94.7	7.7078	75.0577
2025	10	1	13	40	30	29.36	96.1	7.7078	75.5754
2025	10	1	13	50	30	28.21	95.1	7.7017	72.6683
2025	10	1	14	0	30	29.04	95.5	7.7078	74.7989
2025	10	1	14	10	30	28.21	95.1	7.7017	72.6683
2025	10	1	14	20	30	28.36	96.1	7.7078	72.9871
2025	10	1	14	30	30	28.3	94.9	7.6956	72.8666
2025	10	1	14	40	30	28.75	95.8	7.6956	73.9001
2025	10	1	14	50	30	28.88	96.4	7.6956	74.1585
2025	10	1	15	0	30	28.75	95.8	7.7017	73.9613
2025	10	1	15	10	30	28.93	92.6	7.6956	74.6753
2025	10	1	15	20	30	29.35	95.9	7.6956	75.4505
2025	10	1	15	30	30	28.49	94.4	7.6956	73.3834
2025	10	1	15	40	30	29.2	94.7	7.6895	75.1299
2025	10	1	15	50	30	28.78	94.4	7.6956	74.1586

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	1	16	0	30	28.9	94.8	7.6956	74.417
2025	10	1	16	10	30	27.84	92.9	7.6895	71.7736
2025	10	1	16	20	30	28.93	95.4	7.6895	74.3554
2025	10	1	16	30	30	28.2	94.9	7.6895	72.5482
2025	10	1	16	40	30	28.86	93.8	7.6895	74.3555
2025	10	1	16	50	30	29.82	95.2	7.6956	76.7426
2025	10	1	17	0	30	28.63	95.4	7.6834	73.52
2025	10	1	17	10	30	27.86	96.2	7.6895	71.5156
2025	10	1	17	20	30	29.06	93.7	7.6895	74.8719
2025	10	1	17	30	30	28.17	94.1	7.6834	72.4882
2025	10	1	17	40	30	28.47	94	7.6895	73.3228
2025	10	1	17	50	30	29.35	95.9	7.6834	75.3259
2025	10	1	18	0	30	28.22	95.3	7.6895	72.5484
2025	10	1	18	10	30	29.55	93.5	7.6895	76.1629
2025	10	1	18	20	30	29.72	95.2	7.6834	76.3578
2025	10	1	18	30	30	28.17	96.3	7.6895	72.2902
2025	10	1	18	40	30	29.4	94.7	7.6956	75.7092
2025	10	1	18	50	30	28.95	95.7	7.6956	74.4173
2025	10	1	19	0	30	28.56	93.8	7.6895	73.5812
2025	10	1	19	10	30	29.16	93.7	7.6956	75.1925
2025	10	1	19	20	30	28.73	95.4	7.6895	73.8394
2025	10	1	19	30	30	28.83	95.4	7.6956	74.159
2025	10	1	19	40	30	29.57	93.9	7.6956	76.2261
2025	10	1	19	50	30	28.58	94.2	7.6956	73.6422
2025	10	1	20	0	30	29.02	95.1	7.7017	74.7376
2025	10	1	20	10	30	28.58	94.4	7.7017	73.7032
2025	10	1	20	20	30	30.52	95.1	7.7017	78.6167
2025	10	1	20	30	30	29	94.7	7.7017	74.7376
2025	10	1	20	40	30	29.56	96	7.7017	76.0307
2025	10	1	20	50	30	29.47	97.8	7.7017	75.5135
2025	10	1	21	0	30	30.82	95	7.7017	79.3926
2025	10	1	21	10	30	30.2	94.6	7.7017	77.841
2025	10	1	21	20	30	29.73	92.7	7.7017	76.8065
2025	10	1	21	30	30	28.23	95.5	7.7017	72.6688
2025	10	1	21	40	30	29.03	95.3	7.7017	74.7377
2025	10	1	21	50	30	28.7	94.8	7.7017	73.9619
2025	10	1	22	0	30	29.61	95	7.7017	76.2894
2025	10	1	22	10	30	29.72	95.2	7.7017	76.548
2025	10	1	22	20	30	29.24	95.7	7.7017	75.255
2025	10	1	22	30	30	28.44	93	7.7017	73.4447
2025	10	1	22	40	30	29.83	95.4	7.7017	76.8066
2025	10	1	22	50	30	29.13	95.3	7.7017	74.9964
2025	10	1	23	0	30	29.33	95.5	7.7017	75.5136
2025	10	1	23	10	30	28.66	96	7.7017	73.7033
2025	10	1	23	20	30	29.86	93.6	7.7017	77.0653
2025	10	1	23	30	30	29.63	95.4	7.7078	76.3525
2025	10	1	23	40	30	29.27	93.9	7.7017	75.5136
2025	10	1	23	50	30	27.95	93.5	7.7017	72.1517

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	2	0	0	30	27.99	94.5	7.7017	72.1517
2025	10	2	0	10	30	29.94	93.1	7.7078	77.3878
2025	10	2	0	20	30	29.24	95.7	7.7017	75.255
2025	10	2	0	30	30	30.37	96	7.7017	78.0997
2025	10	2	0	40	30	30.55	93.4	7.7078	78.9407
2025	10	2	0	50	30	28.81	95	7.7078	74.2819
2025	10	2	1	0	30	28.7	94.8	7.7078	74.0231
2025	10	2	1	10	30	28.95	95.7	7.7078	74.5408
2025	10	2	1	20	30	30.79	96.3	7.7078	79.1996
2025	10	2	1	30	30	29.56	96	7.7078	76.0937
2025	10	2	1	40	30	29.42	95.1	7.7078	75.8349
2025	10	2	1	50	30	30.02	96.9	7.7078	77.129
2025	10	2	2	0	30	29.01	96.9	7.7078	74.5408
2025	10	2	2	10	30	28.51	95	7.7078	73.5055
2025	10	2	2	20	30	29.87	93.8	7.7078	77.129
2025	10	2	2	30	30	28.86	96	7.7078	74.282
2025	10	2	2	40	30	28.42	95.2	7.7078	73.2467
2025	10	2	2	50	30	29.52	97	7.7078	75.8349
2025	10	2	3	0	30	29.96	95.9	7.7078	77.129
2025	10	2	3	10	30	28.6	96.8	7.7078	73.5055
2025	10	2	3	20	30	30.04	95.5	7.7078	77.3878
2025	10	2	3	30	30	29.32	95.3	7.7078	75.5761
2025	10	2	3	40	30	27.67	93.9	7.7078	71.4349
2025	10	2	3	50	30	28.33	95.5	7.7078	72.9879
2025	10	2	4	0	30	28.92	95.2	7.7078	74.5408
2025	10	2	4	10	30	28.92	95.2	7.7078	74.5408
2025	10	2	4	20	30	29.08	94.3	7.7078	75.0585
2025	10	2	4	30	30	30.28	94.2	7.7139	78.2289
2025	10	2	4	40	30	30.17	94	7.7139	77.9699
2025	10	2	4	50	30	29.56	96	7.7139	76.1566
2025	10	2	5	0	30	29.78	94.2	7.7139	76.9337
2025	10	2	5	10	30	28.13	95.5	7.7139	72.5301
2025	10	2	5	20	30	29.58	94.3	7.7139	76.4157
2025	10	2	5	30	30	28.64	95.6	7.7139	73.8253
2025	10	2	5	40	30	29.86	96	7.7139	76.9338
2025	10	2	5	50	30	30.11	95	7.7139	77.7109
2025	10	2	6	0	30	29.72	95.2	7.7139	76.6747
2025	10	2	6	10	30	29.29	94.5	7.7139	75.6386
2025	10	2	6	20	30	28.93	95.4	7.7139	74.6025
2025	10	2	6	30	30	28.47	94	7.7139	73.5663
2025	10	2	6	40	30	30.47	94	7.7139	78.7471
2025	10	2	6	50	30	29.91	96.7	7.7139	76.9338
2025	10	2	7	0	30	29.86	96	7.7139	76.9338
2025	10	2	7	10	30	29.74	95.6	7.7139	76.6748
2025	10	2	7	20	30	28.07	94.1	7.7139	72.5302
2025	10	2	7	30	30	29.24	95.7	7.7139	75.3797
2025	10	2	7	40	30	29.6	96.6	7.7139	76.1568
2025	10	2	7	50	30	31.14	95.3	7.7139	80.3014

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	2	8	0	30	29.67	94.1	7.7139	76.6748
2025	10	2	8	10	30	29.18	94.3	7.7139	75.3797
2025	10	2	8	20	30	28.72	95.2	7.72	74.1456
2025	10	2	8	30	30	28.53	95.4	7.72	73.6271
2025	10	2	8	40	30	29.22	95.1	7.72	75.4419
2025	10	2	8	50	30	30.07	96.1	7.72	77.5159
2025	10	2	9	0	30	28.86	93.6	7.72	74.6641
2025	10	2	9	10	30	29.47	94.1	7.72	76.2196
2025	10	2	9	20	30	30.22	95.1	7.72	78.0343
2025	10	2	9	30	30	27.96	93.9	7.72	72.3308
2025	10	2	9	40	30	29.42	95.3	7.72	75.9603
2025	10	2	9	50	30	29.51	96.8	7.72	75.9603
2025	10	2	10	0	30	28.59	94.6	7.72	73.8862
2025	10	2	10	10	30	30.27	96.1	7.72	78.0342
2025	10	2	10	20	30	29.49	96.4	7.72	75.9602
2025	10	2	10	30	30	29.36	96.1	7.72	75.7009
2025	10	2	10	40	30	29.08	94.3	7.7261	75.2444
2025	10	2	10	50	30	29.07	93.9	7.72	75.1824
2025	10	2	11	0	30	29.68	94.3	7.7261	76.8012
2025	10	2	11	10	30	29.03	95.3	7.7261	74.9849
2025	10	2	11	20	30	29.53	97.2	7.7261	76.0228
2025	10	2	11	30	30	29.57	96.2	7.7261	76.2822
2025	10	2	11	40	30	29.89	94.4	7.7261	77.3201
2025	10	2	11	50	30	28.78	96.4	7.7261	74.2065
2025	10	2	12	0	30	29.57	97.8	7.7261	76.0227
2025	10	2	12	10	30	29.07	96.1	7.7261	74.9848
2025	10	2	12	20	30	28.33	95.5	7.7261	73.1686
2025	10	2	12	30	30	29.33	95.5	7.7261	75.7632
2025	10	2	12	40	30	28.93	95.4	7.7261	74.7253
2025	10	2	12	50	30	29.68	96.4	7.7261	76.5415
2025	10	2	13	0	30	29.08	94.3	7.7261	75.2442
2025	10	2	13	10	30	29.86	93.6	7.7261	77.3199
2025	10	2	13	20	30	30.09	94.4	7.7322	77.9029
2025	10	2	13	30	30	28.63	95.4	7.7261	73.9468
2025	10	2	13	40	30	29.63	95.4	7.7261	76.5415
2025	10	2	13	50	30	28.68	94.2	7.7322	74.2674
2025	10	2	14	0	30	29.56	96	7.7261	76.282
2025	10	2	14	10	30	29.15	95.9	7.7322	75.3061
2025	10	2	14	20	30	29.46	93.5	7.7322	76.3448
2025	10	2	14	30	30	29.1	96.7	7.7322	75.0464
2025	10	2	14	40	30	28.67	94	7.7322	74.2674
2025	10	2	14	50	30	28.77	94	7.7322	74.5271
2025	10	2	15	0	30	28.92	95.2	7.7261	74.7252
2025	10	2	15	10	30	27.97	94.1	7.7261	72.39
2025	10	2	15	20	30	28.87	96.2	7.72	74.4044
2025	10	2	15	30	30	29.81	94.8	7.7261	77.0604
2025	10	2	15	40	30	29.1	96.7	7.72	74.9229
2025	10	2	15	50	30	28.81	95	7.7261	74.4657

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	2	16	0	30	29.16	93.5	7.7261	75.5036
2025	10	2	16	10	30	29.48	94.3	7.7261	76.2821
2025	10	2	16	20	30	28.98	94.4	7.72	74.923
2025	10	2	16	30	30	29.54	95.6	7.7261	76.2821
2025	10	2	16	40	30	29.99	94.4	7.7322	77.6434
2025	10	2	16	50	30	29.52	95.2	7.7261	76.2821
2025	10	2	17	0	30	27.57	94	7.7261	71.3523
2025	10	2	17	10	30	30.26	95.9	7.7261	78.0984
2025	10	2	17	20	30	28.56	93.6	7.7261	73.947
2025	10	2	17	30	30	29.11	91.6	7.7261	75.5038
2025	10	2	17	40	30	29.46	96	7.7261	76.0227
2025	10	2	17	50	30	29.41	96.8	7.7322	75.8257
2025	10	2	18	0	30	29.18	94.3	7.7322	75.566
2025	10	2	18	10	30	28.81	95	7.7261	74.466
2025	10	2	18	20	30	29.29	94.5	7.7322	75.8258
2025	10	2	18	30	30	29.41	94.9	7.7322	76.0855
2025	10	2	18	40	30	28.72	95.2	7.72	74.1454
2025	10	2	18	50	30	28.91	91.8	7.7383	75.1086
2025	10	2	19	0	30	28.5	94.8	7.7261	73.6877
2025	10	2	19	10	30	28.14	95.7	7.7383	72.7696
2025	10	2	19	20	30	29.33	95.5	7.7322	75.8259
2025	10	2	19	30	30	28.93	95.4	7.7322	74.7872
2025	10	2	19	40	30	30.43	95.3	7.7383	78.7472
2025	10	2	19	50	30	28.98	96.3	7.7322	74.7872
2025	10	2	20	0	30	29.01	96.9	7.7383	74.8488
2025	10	2	20	10	30	28.93	95.4	7.7322	74.7873
2025	10	2	20	20	30	30.57	96	7.7322	78.9421
2025	10	2	20	30	30	29.97	94	7.7444	77.7716
2025	10	2	20	40	30	28.78	96.4	7.7383	74.3291
2025	10	2	20	50	30	28.96	93.6	7.7383	75.1088
2025	10	2	21	0	30	30.11	95	7.7444	78.0317
2025	10	2	21	10	30	28.92	92.2	7.7322	75.047
2025	10	2	21	20	30	30.58	94.1	7.7322	79.2018
2025	10	2	21	30	30	29.71	95	7.7383	76.928
2025	10	2	21	40	30	28.63	95.4	7.7383	74.0692
2025	10	2	21	50	30	28.96	93.6	7.7383	75.1088
2025	10	2	22	0	30	29.51	95.1	7.7383	76.4083
2025	10	2	22	10	30	29.38	94.1	7.7444	76.211
2025	10	2	22	20	30	27.24	93.2	7.7444	70.7488
2025	10	2	22	30	30	30.1	94.8	7.7383	77.9676
2025	10	2	22	40	30	28.86	96	7.7444	74.6504
2025	10	2	22	50	30	29.09	94.5	7.7505	75.4927
2025	10	2	23	0	30	27.34	95.9	7.7444	70.7488
2025	10	2	23	10	30	30.51	94.9	7.7444	79.0722
2025	10	2	23	20	30	28.81	95	7.7505	74.7118
2025	10	2	23	30	30	29.87	93.8	7.7505	77.5753
2025	10	2	23	40	30	28.86	93.8	7.7444	74.9105
2025	10	2	23	50	30	29.24	95.7	7.7505	75.753

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	3	0	0	30	28.69	94.6	7.7505	74.4514
2025	10	3	0	10	30	28.79	94.6	7.7505	74.7117
2025	10	3	0	20	30	28.91	95	7.7565	75.0336
2025	10	3	0	30	30	30.04	95.5	7.7565	77.8995
2025	10	3	0	40	30	29.51	95.1	7.7565	76.5968
2025	10	3	0	50	30	29.02	97.1	7.7505	74.972
2025	10	3	1	0	30	29.35	95.9	7.7505	76.0133
2025	10	3	1	10	30	28.17	96.3	7.7565	72.9493
2025	10	3	1	20	30	29.81	95	7.7565	77.3783
2025	10	3	1	30	30	28.84	95.6	7.7626	74.8344
2025	10	3	1	40	30	29.18	94.3	7.7565	75.8151
2025	10	3	1	50	30	29.05	93.4	7.7505	75.4926
2025	10	3	2	0	30	29.29	94.5	7.7565	76.0757
2025	10	3	2	10	30	29.6	96.6	7.7565	76.5967
2025	10	3	2	20	30	30.29	96.4	7.7565	78.4204
2025	10	3	2	30	30	29.02	95.1	7.7565	75.294
2025	10	3	2	40	30	29.15	95.9	7.7626	75.6166
2025	10	3	2	50	30	29	96.7	7.7565	75.0335
2025	10	3	3	0	30	29.66	96	7.7626	76.9203
2025	10	3	3	10	30	28.98	94.4	7.7687	75.4176
2025	10	3	3	20	30	30.65	95.6	7.7626	79.5278
2025	10	3	3	30	30	29.07	93.9	7.7687	75.6786
2025	10	3	3	40	30	29.81	95	7.7687	77.5053
2025	10	3	3	50	30	29.89	94.4	7.7687	77.7662
2025	10	3	4	0	30	28.96	93.8	7.7565	75.294
2025	10	3	4	10	30	29.42	95.3	7.7687	76.4614
2025	10	3	4	20	30	29.21	96.9	7.7687	75.6785
2025	10	3	4	30	30	30.05	93.2	7.7687	78.2881
2025	10	3	4	40	30	28.92	95.2	7.7748	75.2182
2025	10	3	4	50	30	29.95	95.7	7.7687	77.7662
2025	10	3	5	0	30	28.42	95.2	7.7687	73.8518
2025	10	3	5	10	30	30.28	94.2	7.7809	78.9392
2025	10	3	5	20	30	30	96.7	7.787	77.9574
2025	10	3	5	30	30	31.04	95.4	7.787	80.835
2025	10	3	5	40	30	30.75	93.4	7.787	80.3118
2025	10	3	5	50	30	29.5	94.7	7.787	76.911
2025	10	3	6	0	30	28.83	92.8	7.787	75.3414
2025	10	3	6	10	30	29.43	92.7	7.787	76.911
2025	10	3	6	20	30	28.92	92	7.787	75.6029
2025	10	3	6	30	30	27.56	93.7	7.787	71.9405
2025	10	3	6	40	30	30.44	93	7.787	79.527
2025	10	3	6	50	30	28.38	94.2	7.787	74.0334
2025	10	3	7	0	30	30.07	96.1	7.787	78.219
2025	10	3	7	10	30	28.22	92	7.787	73.7718
2025	10	3	7	20	30	30.66	97.5	7.787	79.527
2025	10	3	7	30	30	28.83	92.6	7.787	75.3414
2025	10	3	7	40	30	29.33	92.7	7.787	76.6494
2025	10	3	7	50	30	30.51	94.9	7.787	79.527

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	3	8	0	30	29.41	94.9	7.7931	76.7121
2025	10	3	8	10	30	28.69	94.6	7.7931	74.8794
2025	10	3	8	20	30	30.4	94.7	7.7931	79.3302
2025	10	3	8	30	30	30.25	95.7	7.7931	78.8066
2025	10	3	8	40	30	30.76	95.8	7.7931	80.1157
2025	10	3	8	50	30	28.96	93.6	7.7931	75.6648
2025	10	3	9	0	30	29.42	95.1	7.7931	76.712
2025	10	3	9	10	30	30.24	95.5	7.7931	78.8065
2025	10	3	9	20	30	29.1	96.7	7.7931	75.6647
2025	10	3	9	30	30	28.98	94.4	7.7931	75.6647
2025	10	3	9	40	30	29.39	94.5	7.7931	76.712
2025	10	3	9	50	30	30.31	94.9	7.7992	79.1329
2025	10	3	10	0	30	29.33	95.5	7.7992	76.5126
2025	10	3	10	10	30	29.65	95.8	7.7992	77.2987
2025	10	3	10	20	30	29.65	95.8	7.7992	77.2987
2025	10	3	10	30	30	30.22	98.4	7.7992	78.3468
2025	10	3	10	40	30	29.7	94.6	7.7931	77.4974
2025	10	3	10	50	30	29.47	96.2	7.7992	76.7746
2025	10	3	11	0	30	30.26	95.9	7.7992	78.8708
2025	10	3	11	10	30	30.21	94.9	7.7992	78.8708
2025	10	3	11	20	30	29.74	98.7	7.7931	76.9737
2025	10	3	11	30	30	28.86	93.6	7.7992	75.4644
2025	10	3	11	40	30	30.02	96.9	7.7931	78.0209
2025	10	3	11	50	30	29.49	98	7.7992	76.5125
2025	10	3	12	0	30	29.28	94.3	7.7992	76.5125
2025	10	3	12	10	30	29.55	93.5	7.8053	77.3616
2025	10	3	12	20	30	29.36	93.5	7.7992	76.7745
2025	10	3	12	30	30	29.72	95.2	7.7992	77.5606
2025	10	3	12	40	30	30	94.8	7.7992	78.3466
2025	10	3	12	50	30	29.97	93.8	7.7992	78.3466
2025	10	3	13	0	30	30.13	95.3	7.7992	78.6086
2025	10	3	13	10	30	29.98	94.2	7.7992	78.3466
2025	10	3	13	20	30	29.64	93.1	7.7992	77.5605
2025	10	3	13	30	30	29.56	96	7.7992	77.0364
2025	10	3	13	40	30	29.86	96	7.7992	77.8225
2025	10	3	13	50	30	30.13	95.3	7.7992	78.6086
2025	10	3	14	0	30	30.03	95.3	7.7992	78.3465
2025	10	3	14	10	30	29.54	95.6	7.7992	77.0364
2025	10	3	14	20	30	30.09	96.5	7.7931	78.2827
2025	10	3	14	30	30	30.03	95.3	7.7992	78.3466
2025	10	3	14	40	30	29.81	94.8	7.7992	77.8225
2025	10	3	14	50	30	29.06	93.7	7.7992	75.9883
2025	10	3	15	0	30	29	94.7	7.7992	75.7263
2025	10	3	15	10	30	29.63	92.7	7.7931	77.4972
2025	10	3	15	20	30	30.1	94.8	7.7931	78.5445
2025	10	3	15	30	30	29.06	95.9	7.7931	75.6646
2025	10	3	15	40	30	29.98	94.2	7.7931	78.2828
2025	10	3	15	50	30	30.41	94.9	7.7931	79.33

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	3	16	0	30	29.48	94.3	7.7931	76.9737
2025	10	3	16	10	30	30.2	94.6	7.7931	78.8065
2025	10	3	16	20	30	29.77	93.9	7.7931	77.7592
2025	10	3	16	30	30	30.5	96.6	7.7931	79.3301
2025	10	3	16	40	30	29.59	94.5	7.7931	77.2356
2025	10	3	16	50	30	29.55	93.5	7.7931	77.2356
2025	10	3	17	0	30	29.62	97	7.7931	76.9739
2025	10	3	17	10	30	29.31	96.9	7.7931	76.1884
2025	10	3	17	20	30	29.59	94.5	7.7931	77.2357
2025	10	3	17	30	30	29.22	95.3	7.7931	76.1885
2025	10	3	17	40	30	29.42	95.1	7.7931	76.7121
2025	10	3	17	50	30	28.7	94.8	7.7931	74.8794
2025	10	3	18	0	30	29.6	96.6	7.7931	76.974
2025	10	3	18	10	30	29.61	95	7.7931	77.2358
2025	10	3	18	20	30	29.76	93.7	7.7931	77.7595
2025	10	3	18	30	30	28.38	94.2	7.7931	74.0941
2025	10	3	18	40	30	29.96	93.6	7.7931	78.2832
2025	10	3	18	50	30	29.11	94.9	7.7931	75.9268
2025	10	3	19	0	30	30.13	95.3	7.7931	78.545
2025	10	3	19	10	30	29.02	95.1	7.7931	75.6651
2025	10	3	19	20	30	29.34	95.7	7.7931	76.4505
2025	10	3	19	30	30	29.62	97	7.7931	76.9742
2025	10	3	19	40	30	29.73	95.4	7.7931	77.4978
2025	10	3	19	50	30	28.73	95.4	7.7931	74.8797
2025	10	3	20	0	30	29.03	95.3	7.7931	75.6651
2025	10	3	20	10	30	29.28	94.3	7.7931	76.4506
2025	10	3	20	20	30	29.91	95	7.7931	78.0215
2025	10	3	20	30	30	30.32	95.1	7.7931	79.0688
2025	10	3	20	40	30	28.68	94.2	7.787	74.8186
2025	10	3	20	50	30	30.99	94.4	7.787	80.8355
2025	10	3	21	0	30	29.22	97.1	7.787	75.865
2025	10	3	21	10	30	30.49	94.5	7.787	79.5275
2025	10	3	21	20	30	29.78	96.4	7.787	77.4347
2025	10	3	21	30	30	29.43	95.5	7.787	76.6499
2025	10	3	21	40	30	29.21	91.8	7.7931	76.4508
2025	10	3	21	50	30	29.32	95.3	7.787	76.3883
2025	10	3	22	0	30	30.26	95.9	7.7931	78.8071
2025	10	3	22	10	30	29.07	93.9	7.7931	75.9271
2025	10	3	22	20	30	30.54	92.8	7.7931	79.8544
2025	10	3	22	30	30	29.11	94.9	7.7931	75.9271
2025	10	3	22	40	30	29.13	95.3	7.7931	75.9272
2025	10	3	22	50	30	29.13	92.6	7.7931	76.189
2025	10	3	23	0	30	29.45	95.8	7.7931	76.7126
2025	10	3	23	10	30	28.66	93.8	7.787	74.8187
2025	10	3	23	20	30	30.18	96.3	7.7931	78.5453
2025	10	3	23	30	30	29.42	95.3	7.787	76.65
2025	10	3	23	40	30	29.48	94.3	7.787	76.9116
2025	10	3	23	50	30	28.25	93.4	7.787	73.7723

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	4	0	0	30	30.4	94.7	7.787	79.266
2025	10	4	0	10	30	27.93	95.5	7.787	72.7259
2025	10	4	0	20	30	30.11	95	7.787	78.4812
2025	10	4	0	30	30	28.93	95.4	7.787	75.3419
2025	10	4	0	40	30	30.1	94.8	7.787	78.4812
2025	10	4	0	50	30	29.47	94.1	7.787	76.9116
2025	10	4	1	0	30	29.55	93.5	7.787	77.1732
2025	10	4	1	10	30	29.15	95.9	7.787	75.8652
2025	10	4	1	20	30	30	96.7	7.787	77.958
2025	10	4	1	30	30	29.91	95	7.787	77.958
2025	10	4	1	40	30	29.82	95.2	7.787	77.6964
2025	10	4	1	50	30	28.94	95.6	7.787	75.3419
2025	10	4	2	0	30	29.32	95.3	7.787	76.3884
2025	10	4	2	10	30	30.52	95.1	7.787	79.5276
2025	10	4	2	20	30	29.11	94.9	7.787	75.8652
2025	10	4	2	30	30	30.6	94.7	7.787	79.7892
2025	10	4	2	40	30	30.3	96.6	7.787	78.7428
2025	10	4	2	50	30	29.19	96.5	7.787	75.8652
2025	10	4	3	0	30	30.41	94.9	7.787	79.2661
2025	10	4	3	10	30	30.31	94.9	7.787	79.0045
2025	10	4	3	20	30	28.49	94.4	7.787	74.2956
2025	10	4	3	30	30	29.18	94.1	7.787	76.1268
2025	10	4	3	40	30	29.66	96	7.787	77.1733
2025	10	4	3	50	30	28.77	96.2	7.787	74.8188
2025	10	4	4	0	30	29.66	96	7.787	77.1733
2025	10	4	4	10	30	28.78	94.4	7.787	75.0805
2025	10	4	4	20	30	29.78	96.4	7.787	77.4349
2025	10	4	4	30	30	30.7	98.1	7.787	79.5278
2025	10	4	4	40	30	30.39	94.3	7.787	79.2662
2025	10	4	4	50	30	29.91	96.7	7.7809	77.633
2025	10	4	5	0	30	29.24	95.7	7.787	76.1269
2025	10	4	5	10	30	30.05	93.4	7.7809	78.4172
2025	10	4	5	20	30	29.7	96.6	7.7809	77.1103
2025	10	4	5	30	30	30.46	95.8	7.7809	79.2015
2025	10	4	5	40	30	29.58	96.4	7.7809	76.8489
2025	10	4	5	50	30	30.1	96.7	7.7809	78.1559
2025	10	4	6	0	30	28.96	95.9	7.7809	75.2806
2025	10	4	6	10	30	29.71	94.8	7.7809	77.3718
2025	10	4	6	20	30	29.52	95.2	7.7809	76.849
2025	10	4	6	30	30	30.44	95.5	7.7809	79.2015
2025	10	4	6	40	30	30.71	94.9	7.7809	79.9857
2025	10	4	6	50	30	31.51	94.7	7.7809	82.0769
2025	10	4	7	0	30	29.03	92.8	7.7809	75.8035
2025	10	4	7	10	30	30.76	95.8	7.7809	79.9858
2025	10	4	7	20	30	29.46	96	7.7809	76.5877
2025	10	4	7	30	30	29.64	95.6	7.7809	77.1105
2025	10	4	7	40	30	29.54	95.6	7.7809	76.8491
2025	10	4	7	50	30	29.94	93.1	7.7809	78.1561

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	4	8	0	30	29.3	94.7	7.7809	76.3264
2025	10	4	8	10	30	29.61	95	7.7809	77.1106
2025	10	4	8	20	30	29.49	96.4	7.7809	76.5878
2025	10	4	8	30	30	29.41	94.9	7.7809	76.5878
2025	10	4	8	40	30	28.14	95.7	7.7809	73.1897
2025	10	4	8	50	30	27.29	94.6	7.7809	71.0986
2025	10	4	9	0	30	28.58	94.2	7.7809	74.4967
2025	10	4	9	10	30	29.89	94.4	7.7809	77.8947
2025	10	4	9	20	30	29.26	93.5	7.7809	76.3264
2025	10	4	9	30	30	29.61	95	7.7809	77.1105
2025	10	4	9	40	30	30.5	94.7	7.7809	79.4631
2025	10	4	9	50	30	29.5	94.7	7.7809	76.8491
2025	10	4	10	0	30	29.08	94.1	7.7809	75.8036
2025	10	4	10	10	30	28.8	94.8	7.7809	75.0194
2025	10	4	10	20	30	28.8	94.8	7.7809	75.0194
2025	10	4	10	30	30	29.76	96	7.7809	77.3719
2025	10	4	10	40	30	29.84	95.6	7.7809	77.6333
2025	10	4	10	50	30	29.77	97.7	7.7809	77.1105
2025	10	4	11	0	30	28.87	96.2	7.7748	74.958
2025	10	4	11	10	30	28.68	94.4	7.7748	74.6968
2025	10	4	11	20	30	29.37	93.9	7.7748	76.525
2025	10	4	11	30	30	29.01	96.9	7.7748	75.2191
2025	10	4	11	40	30	28.69	94.6	7.7748	74.6967
2025	10	4	11	50	30	28.79	96.6	7.7748	74.6967
2025	10	4	12	0	30	29.4	96.6	7.7748	76.2637
2025	10	4	12	10	30	29.71	94.8	7.7809	77.3717
2025	10	4	12	20	30	28.22	95.3	7.7748	73.3907
2025	10	4	12	30	30	29.22	95.3	7.7748	76.0025
2025	10	4	12	40	30	29.87	96.1	7.7748	77.5696
2025	10	4	12	50	30	28.88	94.4	7.7748	75.219
2025	10	4	13	0	30	28.44	95.7	7.7748	73.913
2025	10	4	13	10	30	29.75	95.8	7.7748	77.3083
2025	10	4	13	20	30	28.43	95.4	7.7748	73.913
2025	10	4	13	30	30	29.19	94.5	7.7748	76.0024
2025	10	4	13	40	30	30.44	95.5	7.7748	79.1366
2025	10	4	13	50	30	29.09	94.5	7.7748	75.7412
2025	10	4	14	0	30	30.13	95.3	7.7748	78.353
2025	10	4	14	10	30	28.55	93.4	7.7748	74.4354
2025	10	4	14	20	30	29.72	97	7.7748	77.0471
2025	10	4	14	30	30	30.26	95.9	7.7748	78.6142
2025	10	4	14	40	30	28.78	94.4	7.7748	74.9577
2025	10	4	14	50	30	30.17	96.1	7.7748	78.353
2025	10	4	15	0	30	30.39	96.4	7.7748	78.8753
2025	10	4	15	10	30	30.7	94.7	7.7748	79.9201
2025	10	4	15	20	30	29.26	93.7	7.7687	76.2011
2025	10	4	15	30	30	30	94.6	7.7687	78.0279
2025	10	4	15	40	30	28.85	95.8	7.7687	74.8963
2025	10	4	15	50	30	29.34	95.7	7.7687	76.2012

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	4	16	0	30	29.18	94.1	7.7687	75.9402
2025	10	4	16	10	30	29.52	95.2	7.7687	76.7231
2025	10	4	16	20	30	29.04	93	7.7687	75.6792
2025	10	4	16	30	30	30.32	95.1	7.7687	78.8108
2025	10	4	16	40	30	30.62	95.1	7.7687	79.5937
2025	10	4	16	50	30	29.45	95.8	7.7687	76.4622
2025	10	4	17	0	30	29.63	97.2	7.7687	76.7231
2025	10	4	17	10	30	29.15	95.9	7.7626	75.6173
2025	10	4	17	20	30	30.14	95.5	7.7626	78.2248
2025	10	4	17	30	30	30.18	97.8	7.7626	77.9641
2025	10	4	17	40	30	29.91	95	7.7626	77.7033
2025	10	4	17	50	30	29.75	95.8	7.7626	77.1818
2025	10	4	18	0	30	30.39	96.4	7.7626	78.7463
2025	10	4	18	10	30	29.71	95	7.7626	77.1819
2025	10	4	18	20	30	30.03	97.1	7.7626	77.7034
2025	10	4	18	30	30	29.51	96.8	7.7626	76.3996
2025	10	4	18	40	30	30.5	94.7	7.7626	79.2679
2025	10	4	18	50	30	29.17	96.1	7.7626	75.6174
2025	10	4	19	0	30	29.14	95.7	7.7626	75.6174
2025	10	4	19	10	30	29.51	96.8	7.7626	76.3997
2025	10	4	19	20	30	29.35	97.4	7.7626	75.8782
2025	10	4	19	30	30	29.71	96.8	7.7626	76.9212
2025	10	4	19	40	30	29.82	96.9	7.7626	77.182
2025	10	4	19	50	30	30.04	95.5	7.7626	77.9643
2025	10	4	20	0	30	29.09	96.5	7.7626	75.3568
2025	10	4	20	10	30	29.86	96	7.7626	77.4428
2025	10	4	20	20	30	29.26	93.7	7.7626	76.1391
2025	10	4	20	30	30	30.19	96.5	7.7626	78.2251
2025	10	4	20	40	30	29.13	95.3	7.7626	75.6176
2025	10	4	20	50	30	29.6	94.7	7.7626	76.9214
2025	10	4	21	0	30	28.99	96.5	7.7626	75.0962
2025	10	4	21	10	30	29.81	95	7.7626	77.4429
2025	10	4	21	20	30	29.26	97.7	7.7626	75.6177
2025	10	4	21	30	30	28.17	96.3	7.7626	73.0102
2025	10	4	21	40	30	30.2	96.7	7.7626	78.2252
2025	10	4	21	50	30	29.23	95.5	7.7626	75.8784
2025	10	4	22	0	30	28.87	94	7.7626	75.0962
2025	10	4	22	10	30	30.27	93.8	7.7626	78.7467
2025	10	4	22	20	30	30.25	95.7	7.7626	78.486
2025	10	4	22	30	30	27.7	95	7.7626	71.9672
2025	10	4	22	40	30	29.32	97.1	7.7626	75.8785
2025	10	4	22	50	30	29.28	94.3	7.7626	76.1393
2025	10	4	23	0	30	29.97	96.1	7.7626	77.7038
2025	10	4	23	10	30	30.35	93.2	7.7626	79.0075
2025	10	4	23	20	30	28.92	95.2	7.7626	75.0963
2025	10	4	23	30	30	29	96.7	7.7626	75.0963
2025	10	4	23	40	30	29.69	94.4	7.7626	77.1823
2025	10	4	23	50	30	27.99	94.7	7.7626	72.7495

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	5	0	0	30	29.56	96	7.7626	76.6608
2025	10	5	0	10	30	28.74	95.6	7.7626	74.5748
2025	10	5	0	20	30	28.47	94	7.7626	74.0533
2025	10	5	0	30	30	29.04	95.5	7.7626	75.3571
2025	10	5	0	40	30	29.96	95.9	7.7626	77.7038
2025	10	5	0	50	30	28.41	95	7.7626	73.7926
2025	10	5	1	0	30	28.66	93.6	7.7626	74.5748
2025	10	5	1	10	30	28.12	95.3	7.7626	73.0103
2025	10	5	1	20	30	29.93	95.4	7.7626	77.7039
2025	10	5	1	30	30	29.85	95.8	7.7626	77.4431
2025	10	5	1	40	30	29.85	95.8	7.7626	77.4431
2025	10	5	1	50	30	29.62	95.2	7.7626	76.9216
2025	10	5	2	0	30	29.4	94.7	7.7626	76.4001
2025	10	5	2	10	30	29.78	96.4	7.7626	77.1824
2025	10	5	2	20	30	30.3	96.6	7.7626	78.4861
2025	10	5	2	30	30	28.95	95.7	7.7626	75.0964
2025	10	5	2	40	30	30.33	95.3	7.7626	78.7469
2025	10	5	2	50	30	30.37	94	7.7626	79.0076
2025	10	5	3	0	30	29.85	95.8	7.7626	77.4431
2025	10	5	3	10	30	28.35	93.4	7.7626	73.7926
2025	10	5	3	20	30	29.99	96.5	7.7626	77.7039
2025	10	5	3	30	30	29.14	95.7	7.7626	75.6179
2025	10	5	3	40	30	28.68	94.4	7.7626	74.5749
2025	10	5	3	50	30	29.16	97.7	7.7626	75.3572
2025	10	5	4	0	30	29.85	95.8	7.7626	77.4432
2025	10	5	4	10	30	29.6	94.7	7.7626	76.9217
2025	10	5	4	20	30	29.81	95	7.7626	77.4432
2025	10	5	4	30	30	29.44	95.7	7.7626	76.4002
2025	10	5	4	40	30	28.8	94.8	7.7626	74.8357
2025	10	5	4	50	30	29.78	94.2	7.7626	77.4432
2025	10	5	5	0	30	29.62	95.2	7.7626	76.9217
2025	10	5	5	10	30	30.19	96.5	7.7626	78.2255
2025	10	5	5	20	30	29.56	93.7	7.7626	76.9217
2025	10	5	5	30	30	30.41	96.8	7.7626	78.747
2025	10	5	5	40	30	30.01	95	7.7626	77.9648
2025	10	5	5	50	30	29.56	96	7.7626	76.661
2025	10	5	6	0	30	30.14	97.2	7.7626	77.9648
2025	10	5	6	10	30	29.77	94	7.7626	77.4433
2025	10	5	6	20	30	29.28	94.1	7.7626	76.1395
2025	10	5	6	30	30	29.33	95.5	7.7626	76.1396
2025	10	5	6	40	30	29.26	97.7	7.7626	75.6181
2025	10	5	6	50	30	30.99	96.3	7.7626	80.3116
2025	10	5	7	0	30	28.97	94	7.7626	75.3573
2025	10	5	7	10	30	30.24	95.5	7.7626	78.4864
2025	10	5	7	20	30	29.75	95.8	7.7626	77.1826
2025	10	5	7	30	30	28.45	93.4	7.7626	74.0536
2025	10	5	7	40	30	27.89	94.5	7.7626	72.4891
2025	10	5	7	50	30	28.08	94.3	7.7626	73.0106

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	5	8	0	30	28.24	97.5	7.7626	73.0106
2025	10	5	8	10	30	27.86	93.9	7.7626	72.4891
2025	10	5	8	20	30	29.3	94.7	7.7626	76.1397
2025	10	5	8	30	30	28.39	94.6	7.7626	73.7929
2025	10	5	8	40	30	28.85	95.8	7.7626	74.8359
2025	10	5	8	50	30	30.88	96.1	7.7626	80.051
2025	10	5	9	0	30	29.3	94.7	7.7626	76.1396
2025	10	5	9	10	30	28.85	93.4	7.7626	75.0966
2025	10	5	9	20	30	29.08	94.1	7.7626	75.6181
2025	10	5	9	30	30	31.18	94	7.7626	81.0939
2025	10	5	9	40	30	30.41	96.8	7.7626	78.7471
2025	10	5	9	50	30	28.56	96	7.7626	74.0536
2025	10	5	10	0	30	29.77	94	7.7687	77.5068
2025	10	5	10	10	30	29.71	95	7.7687	77.2458
2025	10	5	10	20	30	28.68	94.4	7.7687	74.6362
2025	10	5	10	30	30	30.07	94	7.7687	78.2897
2025	10	5	10	40	30	28.99	94.6	7.7687	75.419
2025	10	5	10	50	30	28.92	95.2	7.7687	75.1581
2025	10	5	11	0	30	29.13	99.9	7.7687	74.8971
2025	10	5	11	10	30	29.06	93.7	7.7687	75.6799
2025	10	5	11	20	30	29.53	95.4	7.7687	76.7238
2025	10	5	11	30	30	28.92	95.2	7.7687	75.158
2025	10	5	11	40	30	28.93	95.4	7.7687	75.158
2025	10	5	11	50	30	30.2	94.7	7.7687	78.5505
2025	10	5	12	0	30	29.84	95.6	7.7687	77.5066
2025	10	5	12	10	30	29.41	94.9	7.7687	76.4628
2025	10	5	12	20	30	27.99	94.7	7.7687	72.8092
2025	10	5	12	30	30	30.12	96.9	7.7687	78.0285
2025	10	5	12	40	30	29.7	96.6	7.7687	76.9846
2025	10	5	12	50	30	30.14	97.2	7.7687	78.0285
2025	10	5	13	0	30	30.81	96.7	7.7687	79.8552
2025	10	5	13	10	30	29.29	96.5	7.7687	75.9408
2025	10	5	13	20	30	29.7	96.6	7.7687	76.9846
2025	10	5	13	30	30	30.85	97.3	7.7687	79.8552
2025	10	5	13	40	30	29.35	95.9	7.7687	76.2017
2025	10	5	13	50	30	29.9	94.6	7.7687	77.7675
2025	10	5	14	0	30	30	94.8	7.7687	78.0284
2025	10	5	14	10	30	28.63	95.4	7.7687	74.3749
2025	10	5	14	20	30	30.32	95.1	7.7687	78.8113
2025	10	5	14	30	30	29.81	96.7	7.7687	77.2455
2025	10	5	14	40	30	29.88	94.2	7.7687	77.7675
2025	10	5	14	50	30	30.4	96.6	7.7687	78.8113
2025	10	5	15	0	30	29.42	95.3	7.7687	76.4627
2025	10	5	15	10	30	28.69	94.6	7.7626	74.5747
2025	10	5	15	20	30	30.3	94.5	7.7626	78.7468
2025	10	5	15	30	30	29.06	93.7	7.7687	75.6798
2025	10	5	15	40	30	29.32	95.3	7.7626	76.1393
2025	10	5	15	50	30	29.45	95.8	7.7687	76.4627

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	5	16	0	30	29.94	95.6	7.7626	77.7038
2025	10	5	16	10	30	29.4	94.7	7.7687	76.4627
2025	10	5	16	20	30	29.03	95.3	7.7626	75.3571
2025	10	5	16	30	30	29.85	93.3	7.7687	77.7676
2025	10	5	16	40	30	28.51	95	7.7626	74.0534
2025	10	5	16	50	30	29.56	96	7.7626	76.6609
2025	10	5	17	0	30	29.23	95.5	7.7626	75.8787
2025	10	5	17	10	30	29.61	96.8	7.7626	76.661
2025	10	5	17	20	30	28.46	96.1	7.7626	73.7927
2025	10	5	17	30	30	29.72	95.2	7.7626	77.1825
2025	10	5	17	40	30	29.4	94.7	7.7626	76.4003
2025	10	5	17	50	30	30.47	96	7.7687	79.0726
2025	10	5	18	0	30	28.91	97	7.7626	74.8358
2025	10	5	18	10	30	29.04	98.7	7.7626	74.8358
2025	10	5	18	20	30	30.23	97	7.7626	78.2256
2025	10	5	18	30	30	31.18	97.7	7.7626	80.5724
2025	10	5	18	40	30	30.05	97.5	7.7626	77.7042
2025	10	5	18	50	30	29.73	97.1	7.7626	76.9219
2025	10	5	19	0	30	29.32	95.3	7.7626	76.1397
2025	10	5	19	10	30	30.27	96.1	7.7626	78.4865
2025	10	5	19	20	30	29.49	94.5	7.7626	76.6613
2025	10	5	19	30	30	29.61	96.8	7.7626	76.6613
2025	10	5	19	40	30	29.84	98.7	7.7626	76.9221
2025	10	5	19	50	30	29.61	95	7.7626	76.9221
2025	10	5	20	0	30	30.63	95.2	7.7626	79.5296
2025	10	5	20	10	30	29.47	96.2	7.7626	76.4006
2025	10	5	20	20	30	30.42	95.1	7.7626	79.0082
2025	10	5	20	30	30	29.7	94.6	7.7626	77.1829
2025	10	5	20	40	30	30.08	96.3	7.7626	77.9652
2025	10	5	20	50	30	30.18	94.2	7.7626	78.4867
2025	10	5	21	0	30	28.77	96.2	7.7626	74.5754
2025	10	5	21	10	30	29.9	94.6	7.7626	77.7045
2025	10	5	21	20	30	29.97	96.1	7.7626	77.7045
2025	10	5	21	30	30	29.7	96.6	7.7626	76.9223
2025	10	5	21	40	30	31.33	95.3	7.7687	81.4218
2025	10	5	21	50	30	29.42	95.1	7.7687	76.4634
2025	10	5	22	0	30	31.3	94.6	7.7687	81.4218
2025	10	5	22	10	30	30.89	96.3	7.7626	80.0513
2025	10	5	22	20	30	30.49	96.4	7.7687	79.0731
2025	10	5	22	30	30	29.77	93.9	7.7687	77.5073
2025	10	5	22	40	30	29.77	93.9	7.7687	77.5073
2025	10	5	22	50	30	30.43	95.3	7.7687	79.0731
2025	10	5	23	0	30	30.07	96.1	7.7687	78.0293
2025	10	5	23	10	30	30.11	95	7.7687	78.2902
2025	10	5	23	20	30	29.77	96.2	7.7687	77.2464
2025	10	5	23	30	30	29.16	93.7	7.7687	75.9415
2025	10	5	23	40	30	30.11	95	7.7687	78.2902
2025	10	5	23	50	30	29.66	97.6	7.7687	76.7244

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	6	0	0	30	30	94.6	7.7687	78.0293
2025	10	6	0	10	30	30.83	95.2	7.7687	80.117
2025	10	6	0	20	30	30.01	95	7.7687	78.0293
2025	10	6	0	30	30	31.21	96.6	7.7687	80.8999
2025	10	6	0	40	30	29.75	95.8	7.7687	77.2464
2025	10	6	0	50	30	29.74	95.6	7.7687	77.2464
2025	10	6	1	0	30	29.13	95.5	7.7687	75.6806
2025	10	6	1	10	30	29.19	94.5	7.7687	75.9416
2025	10	6	1	20	30	29.42	95.3	7.7687	76.4635
2025	10	6	1	30	30	28.9	94.8	7.7687	75.1586
2025	10	6	1	40	30	30.07	94	7.7687	78.2902
2025	10	6	1	50	30	28.36	93.6	7.7687	73.8538
2025	10	6	2	0	30	30.36	95.9	7.7687	78.8122
2025	10	6	2	10	30	30.1	94.8	7.7687	78.2902
2025	10	6	2	20	30	28.35	93.2	7.7687	73.8538
2025	10	6	2	30	30	28.32	95.3	7.7687	73.5928
2025	10	6	2	40	30	29.65	95.8	7.7748	77.0485
2025	10	6	2	50	30	29.47	94.1	7.7748	76.7873
2025	10	6	3	0	30	29.91	96.7	7.7748	77.5708
2025	10	6	3	10	30	29.94	95.6	7.7748	77.832
2025	10	6	3	20	30	30.1	94.6	7.7748	78.3544
2025	10	6	3	30	30	29.28	94.1	7.7687	76.2025
2025	10	6	3	40	30	29.81	95	7.7748	77.5708
2025	10	6	3	50	30	28.6	94.8	7.7748	74.4367
2025	10	6	4	0	30	30.54	95.4	7.7748	79.3991
2025	10	6	4	10	30	29.41	96.8	7.7748	76.2649
2025	10	6	4	20	30	29.95	97.5	7.7748	77.5709
2025	10	6	4	30	30	30.49	96.4	7.7748	79.138
2025	10	6	4	40	30	29.32	95.1	7.7748	76.265
2025	10	6	4	50	30	27.82	95.4	7.7748	72.3473
2025	10	6	5	0	30	29.06	93.7	7.7748	75.7426
2025	10	6	5	10	30	29.59	94.5	7.7748	77.0485
2025	10	6	5	20	30	29.47	94.1	7.7748	76.7874
2025	10	6	5	30	30	29.75	95.8	7.7748	77.3097
2025	10	6	5	40	30	29.12	97.1	7.7748	75.4815
2025	10	6	5	50	30	30.05	95.7	7.7748	78.0933
2025	10	6	6	0	30	29.1	94.7	7.7748	75.7427
2025	10	6	6	10	30	30.99	96.3	7.7748	80.4439
2025	10	6	6	20	30	30.45	95.7	7.7748	79.138
2025	10	6	6	30	30	29.54	95.6	7.7748	76.7874
2025	10	6	6	40	30	29.56	96	7.7748	76.7874
2025	10	6	6	50	30	29.86	97.5	7.7748	77.3098
2025	10	6	7	0	30	29.08	96.3	7.7748	75.4815
2025	10	6	7	10	30	30.29	96.4	7.7748	78.6157
2025	10	6	7	20	30	29.91	95	7.7809	77.8959
2025	10	6	7	30	30	30.02	96.9	7.7809	77.8959
2025	10	6	7	40	30	29.55	95.8	7.7809	76.8503
2025	10	6	7	50	30	29.54	95.6	7.787	76.9132

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	6	8	0	30	30.41	96.8	7.787	79.0061
2025	10	6	8	10	30	30.59	96.4	7.787	79.5294
2025	10	6	8	20	30	29.29	94.5	7.787	76.39
2025	10	6	8	30	30	29.63	95.4	7.787	77.1749
2025	10	6	8	40	30	27.95	93.5	7.7931	73.0488
2025	10	6	8	50	30	29.51	94.9	7.7931	76.9761
2025	10	6	9	0	30	29.06	95.9	7.7931	75.667
2025	10	6	9	10	30	29.22	95.3	7.7931	76.1906
2025	10	6	9	20	30	28.99	94.6	7.7992	75.7287
2025	10	6	9	30	30	28.84	93.2	7.7931	75.4051
2025	10	6	9	40	30	30.24	95.5	7.7992	78.8731
2025	10	6	9	50	30	29.81	95	7.7992	77.825
2025	10	6	10	0	30	29.36	96.1	7.7931	76.4523
2025	10	6	10	10	30	29.66	96	7.8053	77.364
2025	10	6	10	20	30	29.5	96.6	7.8053	76.8394
2025	10	6	10	30	30	29.46	97.6	7.7992	76.5147
2025	10	6	10	40	30	28.62	95.2	7.7992	74.6804
2025	10	6	10	50	30	30.43	95.3	7.7992	79.3971
2025	10	6	11	0	30	29.88	96.3	7.7992	77.8248
2025	10	6	11	10	30	30.21	94.9	7.7992	78.8729
2025	10	6	11	20	30	29.92	95.2	7.7931	78.0231
2025	10	6	11	30	30	30.05	95.7	7.7931	78.2849
2025	10	6	11	40	30	29.71	95	7.7931	77.4994
2025	10	6	11	50	30	30.06	95.9	7.7992	78.3488
2025	10	6	12	0	30	30.57	96	7.7931	79.5939
2025	10	6	12	10	30	30.29	96.4	7.7931	78.8084
2025	10	6	12	20	30	28.48	96.5	7.7931	74.0956
2025	10	6	12	30	30	30.01	95	7.7931	78.2848
2025	10	6	12	40	30	30.47	96	7.7931	79.332
2025	10	6	12	50	30	30.14	95.5	7.7931	78.5465
2025	10	6	13	0	30	31.07	95.9	7.7931	80.9029
2025	10	6	13	10	30	29.33	95.5	7.7931	76.452
2025	10	6	13	20	30	30.68	97.7	7.787	79.5288
2025	10	6	13	30	30	30.2	96.7	7.787	78.4823
2025	10	6	13	40	30	29.67	96.2	7.787	77.1743
2025	10	6	13	50	30	29.65	93.3	7.787	77.4359
2025	10	6	14	0	30	29.45	97.4	7.787	76.3895
2025	10	6	14	10	30	29.94	95.6	7.787	77.9591
2025	10	6	14	20	30	29.7	96.6	7.787	77.1743
2025	10	6	14	30	30	31.05	95.5	7.787	80.8368
2025	10	6	14	40	30	29.9	98.1	7.787	77.4359
2025	10	6	14	50	30	29.77	96.2	7.787	77.4359
2025	10	6	15	0	30	28.83	95.4	7.7809	75.02
2025	10	6	15	10	30	30.45	95.7	7.7809	79.2023
2025	10	6	15	20	30	28.68	94.4	7.7809	74.7586
2025	10	6	15	30	30	30.58	96.2	7.7809	79.4637
2025	10	6	15	40	30	28.79	94.6	7.7809	75.0201
2025	10	6	15	50	30	29.7	96.6	7.7809	77.1112

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	6	16	0	30	28.93	95.4	7.7809	75.2815
2025	10	6	16	10	30	29.83	97.1	7.7809	77.3726
2025	10	6	16	20	30	28.13	95.5	7.7809	73.1903
2025	10	6	16	30	30	30.92	95	7.7809	80.5094
2025	10	6	16	40	30	30.7	98.1	7.7809	79.4638
2025	10	6	16	50	30	30.14	97.2	7.7809	78.1569
2025	10	6	17	0	30	29.76	97.5	7.7809	77.1113
2025	10	6	17	10	30	31.33	97	7.7809	81.2936
2025	10	6	17	20	30	30.17	97.6	7.7809	78.1569
2025	10	6	17	30	30	29.53	95.4	7.7809	76.85
2025	10	6	17	40	30	30.06	95.9	7.7809	78.1569
2025	10	6	17	50	30	29.63	95.4	7.7809	77.1114
2025	10	6	18	0	30	30.09	94.4	7.7809	78.4184
2025	10	6	18	10	30	29.92	95.2	7.7809	77.8956
2025	10	6	18	20	30	28.29	94.7	7.7809	73.7133
2025	10	6	18	30	30	28.08	94.3	7.7809	73.1905
2025	10	6	18	40	30	29.77	96.2	7.7809	77.3729
2025	10	6	18	50	30	30.05	95.7	7.7809	78.1571
2025	10	6	19	0	30	30.6	96.6	7.787	79.5291
2025	10	6	19	10	30	28.62	95.2	7.787	74.5585
2025	10	6	19	20	30	30.69	96.4	7.787	79.7908
2025	10	6	19	30	30	30.45	95.7	7.787	79.2676
2025	10	6	19	40	30	30.33	95.3	7.787	79.006
2025	10	6	19	50	30	27.22	95.3	7.787	70.8961
2025	10	6	20	0	30	29.15	98.9	7.787	75.3435
2025	10	6	20	10	30	28.21	95.1	7.7931	73.5723
2025	10	6	20	20	30	30.43	95.3	7.787	79.2677
2025	10	6	20	30	30	28.95	95.7	7.7931	75.4051
2025	10	6	20	40	30	29.54	92.9	7.7931	77.2379
2025	10	6	20	50	30	28.99	94.6	7.7992	75.7288
2025	10	6	21	0	30	29.6	96.6	7.7931	76.9761
2025	10	6	21	10	30	29.61	94.8	7.7992	77.3011
2025	10	6	21	20	30	29.81	95	7.7992	77.8251
2025	10	6	21	30	30	29.47	94.1	7.8053	77.1019
2025	10	6	21	40	30	29.08	96.3	7.8053	75.7907
2025	10	6	21	50	30	30.47	94	7.8053	79.7245
2025	10	6	22	0	30	28.64	93.2	7.8053	75.004
2025	10	6	22	10	30	29.92	95.2	7.8053	78.151
2025	10	6	22	20	30	29.74	95.6	7.8053	77.6265
2025	10	6	22	30	30	30.07	96.1	7.8053	78.4133
2025	10	6	22	40	30	30.05	95.7	7.8053	78.4133
2025	10	6	22	50	30	29.45	95.8	7.8053	76.8398
2025	10	6	23	0	30	30.07	96.1	7.8053	78.4133
2025	10	6	23	10	30	30.34	95.5	7.8053	79.2001
2025	10	6	23	20	30	29.87	96.1	7.8053	77.8888
2025	10	6	23	30	30	29.77	94	7.8053	77.8888
2025	10	6	23	40	30	29.49	94.5	7.8053	77.1021
2025	10	6	23	50	30	28.9	94.8	7.8053	75.5286

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	7	0	0	30	30.79	94.5	7.8053	80.5114
2025	10	7	0	10	30	29.95	95.7	7.8053	78.1511
2025	10	7	0	20	30	29.12	95.1	7.8053	76.0531
2025	10	7	0	30	30	29.92	92.1	7.8114	78.4773
2025	10	7	0	40	30	28.93	92.8	7.8114	75.8526
2025	10	7	0	50	30	30.22	95.1	7.8114	79.0022
2025	10	7	1	0	30	29.25	95.9	7.8114	76.3776
2025	10	7	1	10	30	30.31	94.9	7.8114	79.2647
2025	10	7	1	20	30	28.6	94.8	7.8114	74.8028
2025	10	7	1	30	30	28.86	96	7.8114	75.3277
2025	10	7	1	40	30	28.19	94.5	7.8114	73.7529
2025	10	7	1	50	30	29.45	93.3	7.8114	77.165
2025	10	7	2	0	30	29.48	94.3	7.8114	77.165
2025	10	7	2	10	30	30.46	97.5	7.8114	79.2647
2025	10	7	2	20	30	29.91	95	7.8114	78.2148
2025	10	7	2	30	30	28.23	95.5	7.8114	73.7529
2025	10	7	2	40	30	27.92	95.3	7.8114	72.9655
2025	10	7	2	50	30	29.24	95.7	7.8114	76.3776
2025	10	7	3	0	30	30.67	93.9	7.8114	80.3145
2025	10	7	3	10	30	30.35	95.7	7.8114	79.2647
2025	10	7	3	20	30	30.41	94.9	7.8114	79.5271
2025	10	7	3	30	30	28.42	97.1	7.8114	74.0154
2025	10	7	3	40	30	30.3	94.7	7.8175	79.3293
2025	10	7	3	50	30	30.24	95.5	7.8114	79.0022
2025	10	7	4	0	30	30.65	95.6	7.8114	80.0521
2025	10	7	4	10	30	30.99	96.3	7.8175	80.9054
2025	10	7	4	20	30	29.49	96.4	7.8175	76.9652
2025	10	7	4	30	30	29.42	95.3	7.8175	76.9652
2025	10	7	4	40	30	29.1	96.7	7.8175	75.9145
2025	10	7	4	50	30	29.49	94.5	7.8175	77.2279
2025	10	7	5	0	30	29.13	95.5	7.8175	76.1771
2025	10	7	5	10	30	30.19	96.5	7.8175	78.8039
2025	10	7	5	20	30	30.39	96.4	7.8175	79.3293
2025	10	7	5	30	30	29.14	93.1	7.8175	76.4398
2025	10	7	5	40	30	29.5	94.7	7.8175	77.2279
2025	10	7	5	50	30	29.16	93.7	7.8175	76.4399
2025	10	7	6	0	30	29.94	95.6	7.8175	78.2786
2025	10	7	6	10	30	29.15	95.9	7.8175	76.1772
2025	10	7	6	20	30	29.35	95.9	7.8175	76.7026
2025	10	7	6	30	30	29.7	94.6	7.8175	77.7533
2025	10	7	6	40	30	30.7	94.7	7.8175	80.3801
2025	10	7	6	50	30	30.27	94	7.8175	79.3294
2025	10	7	7	0	30	28.98	94.4	7.8175	75.9146
2025	10	7	7	10	30	29.71	95	7.8175	77.7533
2025	10	7	7	20	30	29.75	95.8	7.8175	77.7534
2025	10	7	7	30	30	28.98	94.2	7.8236	75.9764
2025	10	7	7	40	30	30.6	96.6	7.8175	79.8548
2025	10	7	7	50	30	29.4	94.7	7.8175	76.9654

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	7	8	0	30	30.3	94.7	7.8175	79.3295
2025	10	7	8	10	30	30.02	95.2	7.8175	78.5415
2025	10	7	8	20	30	29.48	94.3	7.8236	77.2909
2025	10	7	8	30	30	29.6	96.6	7.8236	77.2909
2025	10	7	8	40	30	29.42	95.1	7.8236	77.028
2025	10	7	8	50	30	29.34	95.7	7.8236	76.7651
2025	10	7	9	0	30	30.15	95.7	7.8236	78.8682
2025	10	7	9	10	30	29.32	95.1	7.8236	76.7651
2025	10	7	9	20	30	28.38	94.2	7.8236	74.399
2025	10	7	9	30	30	29.43	95.5	7.8236	77.0279
2025	10	7	9	40	30	28.52	95.2	7.8236	74.6619
2025	10	7	9	50	30	29.77	93.9	7.8236	78.0795
2025	10	7	10	0	30	28.63	97.2	7.8236	74.6618
2025	10	7	10	10	30	29.25	95.9	7.8236	76.5021
2025	10	7	10	20	30	29.55	95.8	7.8297	77.3536
2025	10	7	10	30	30	29.75	93.5	7.8297	78.1429
2025	10	7	10	40	30	30.63	95.2	7.8297	80.2478
2025	10	7	10	50	30	28.56	96	7.8297	74.7225
2025	10	7	11	0	30	29.88	94.2	7.8297	78.406
2025	10	7	11	10	30	30.41	94.9	7.8297	79.7215
2025	10	7	11	20	30	29.88	96.3	7.8297	78.1428
2025	10	7	11	30	30	29.2	94.7	7.8297	76.5642
2025	10	7	11	40	30	29.77	96.2	7.8297	77.8797
2025	10	7	11	50	30	29.04	95.5	7.8297	76.0379
2025	10	7	12	0	30	30.18	96.3	7.8297	78.932
2025	10	7	12	10	30	29.61	96.8	7.8297	77.3534
2025	10	7	12	20	30	30.07	97.6	7.8297	78.4058
2025	10	7	12	30	30	29.6	96.6	7.8297	77.3534
2025	10	7	12	40	30	29.88	96.3	7.8297	78.1427
2025	10	7	12	50	30	30.81	94.8	7.8297	80.7737
2025	10	7	13	0	30	30.49	96.4	7.8297	79.7213
2025	10	7	13	10	30	29.61	98.3	7.8297	77.0902
2025	10	7	13	20	30	28.56	96	7.8297	74.7222
2025	10	7	13	30	30	29.13	95.5	7.8297	76.3008
2025	10	7	13	40	30	29.39	96.4	7.8297	76.827
2025	10	7	13	50	30	29.24	95.7	7.8297	76.5639
2025	10	7	14	0	30	29.88	94.2	7.8297	78.4057
2025	10	7	14	10	30	29.7	98.1	7.8297	77.3532
2025	10	7	14	20	30	29.53	97.2	7.8297	77.0901
2025	10	7	14	30	30	29.67	97.7	7.8297	77.3532
2025	10	7	14	40	30	29.53	92.5	7.8297	77.6163
2025	10	7	14	50	30	28.49	94.6	7.8297	74.7222
2025	10	7	15	0	30	29.66	96	7.8297	77.6163
2025	10	7	15	10	30	29.97	96.1	7.8297	78.4057
2025	10	7	15	20	30	29.79	94.4	7.8297	78.1425
2025	10	7	15	30	30	29.59	94.5	7.8297	77.6163
2025	10	7	15	40	30	29.51	96.8	7.8297	77.0901
2025	10	7	15	50	30	30.18	94.2	7.8297	79.195

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	7	16	0	30	28.5	96.9	7.8297	74.4591
2025	10	7	16	10	30	29.55	95.8	7.8297	77.3533
2025	10	7	16	20	30	29.42	95.1	7.8297	77.0902
2025	10	7	16	30	30	29.44	95.7	7.8297	77.0902
2025	10	7	16	40	30	29.74	95.6	7.8358	77.9428
2025	10	7	16	50	30	30.15	95.7	7.8297	78.932
2025	10	7	17	0	30	29.68	96.4	7.8297	77.6165
2025	10	7	17	10	30	29.74	97.3	7.8297	77.6165
2025	10	7	17	20	30	30.09	94.4	7.8297	78.932
2025	10	7	17	30	30	30.51	96.8	7.8297	79.7214
2025	10	7	17	40	30	29.51	95.1	7.8297	77.3534
2025	10	7	17	50	30	31.91	94.7	7.8297	83.668
2025	10	7	18	0	30	29.92	95.2	7.8358	78.4696
2025	10	7	18	10	30	29.86	96	7.8358	78.2063
2025	10	7	18	20	30	29.86	96	7.8358	78.2063
2025	10	7	18	30	30	31.18	96.1	7.8297	81.5632
2025	10	7	18	40	30	30.04	95.5	7.8358	78.733
2025	10	7	18	50	30	29.45	95.8	7.8358	77.1531
2025	10	7	19	0	30	29.54	95.6	7.8358	77.4165
2025	10	7	19	10	30	30.04	95.5	7.8358	78.7331
2025	10	7	19	20	30	29.5	94.7	7.8358	77.4165
2025	10	7	19	30	30	30.72	95	7.8358	80.5764
2025	10	7	19	40	30	29.25	95.9	7.8358	76.6266
2025	10	7	19	50	30	30.39	94.3	7.8358	79.7865
2025	10	7	20	0	30	30.37	94	7.8358	79.7865
2025	10	7	20	10	30	30.28	96.3	7.8358	79.2599
2025	10	7	20	20	30	30.26	95.9	7.8358	79.2599
2025	10	7	20	30	30	29.5	94.7	7.8358	77.4167
2025	10	7	20	40	30	30.91	94.8	7.8358	81.1032
2025	10	7	20	50	30	29.46	96	7.8358	77.1534
2025	10	7	21	0	30	31.3	97.9	7.8358	81.6298
2025	10	7	21	10	30	29.81	94.8	7.8358	78.2067
2025	10	7	21	20	30	29.34	95.7	7.8358	76.8901
2025	10	7	21	30	30	30.3	94.7	7.8358	79.5233
2025	10	7	21	40	30	30.09	94.4	7.8358	78.9967
2025	10	7	21	50	30	29.72	95.2	7.8358	77.9434
2025	10	7	22	0	30	30.17	93.8	7.8358	79.26
2025	10	7	22	10	30	30.71	94.9	7.8358	80.5766
2025	10	7	22	20	30	29.99	96.5	7.8419	78.5338
2025	10	7	22	30	30	30.01	95	7.8358	78.7334
2025	10	7	22	40	30	30.17	94	7.8419	79.3244
2025	10	7	22	50	30	30.01	95	7.8419	78.7974
2025	10	7	23	0	30	30.21	94.9	7.8419	79.3244
2025	10	7	23	10	30	30.67	93.9	7.8419	80.6421
2025	10	7	23	20	30	29.09	94.5	7.8419	76.4256
2025	10	7	23	30	30	29.22	95.3	7.8419	76.6891
2025	10	7	23	40	30	30.3	94.5	7.8419	79.588
2025	10	7	23	50	30	30.35	95.7	7.8419	79.588

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	8	0	0	30	31.23	97	7.8419	81.6963
2025	10	8	0	10	30	30.48	94.1	7.848	80.1801
2025	10	8	0	20	30	30.19	94.4	7.848	79.3889
2025	10	8	0	30	30	29.41	94.9	7.8541	77.3416
2025	10	8	0	40	30	28.9	96.8	7.8541	75.7578
2025	10	8	0	50	30	29.32	95.1	7.848	77.0152
2025	10	8	1	0	30	30.09	96.5	7.848	78.8614
2025	10	8	1	10	30	29.79	96.6	7.8541	78.1335
2025	10	8	1	20	30	30.15	95.7	7.8602	79.2535
2025	10	8	1	30	30	28.89	94.6	7.8541	76.0218
2025	10	8	1	40	30	30.91	94.8	7.8541	81.3011
2025	10	8	1	50	30	29.35	95.9	7.8602	77.1401
2025	10	8	2	0	30	29.31	94.9	7.8602	77.1401
2025	10	8	2	10	30	30.62	95.1	7.8602	80.5744
2025	10	8	2	20	30	29.33	95.5	7.8602	77.1401
2025	10	8	2	30	30	30.99	96.3	7.8663	81.4328
2025	10	8	2	40	30	30.14	95.5	7.8602	79.2535
2025	10	8	2	50	30	30.2	94.6	7.8663	79.5821
2025	10	8	3	0	30	29.11	94.9	7.8602	76.6117
2025	10	8	3	10	30	31.42	94.9	7.8602	82.6878
2025	10	8	3	20	30	29.11	94.9	7.8602	76.6117
2025	10	8	3	30	30	29.06	95.9	7.8663	76.4094
2025	10	8	3	40	30	29.82	95.2	7.8663	78.5245
2025	10	8	3	50	30	30.45	93.2	7.8663	80.3753
2025	10	8	4	0	30	28.89	94.6	7.8663	76.145
2025	10	8	4	10	30	27.71	91.4	7.8663	73.2367
2025	10	8	4	20	30	30	94.6	7.8663	79.0533
2025	10	8	4	30	30	28.58	94.4	7.8663	75.3518
2025	10	8	4	40	30	30.58	94.1	7.8663	80.6397
2025	10	8	4	50	30	30.02	95.2	7.8663	79.0533
2025	10	8	5	0	30	30.09	96.5	7.8663	79.0533
2025	10	8	5	10	30	29.68	94.3	7.8663	78.2602
2025	10	8	5	20	30	30.26	95.9	7.8663	79.5821
2025	10	8	5	30	30	29.32	92.3	7.8724	77.5297
2025	10	8	5	40	30	30.59	96.4	7.8724	80.4403
2025	10	8	5	50	30	29.93	95.4	7.8724	78.8527
2025	10	8	6	0	30	29.89	94.4	7.8724	78.8527
2025	10	8	6	10	30	28.96	93.8	7.8724	76.4713
2025	10	8	6	20	30	30.96	93.7	7.8724	81.7634
2025	10	8	6	30	30	29.93	95.4	7.8724	78.8528
2025	10	8	6	40	30	29.89	94.4	7.8724	78.8528
2025	10	8	6	50	30	29.54	95.6	7.8724	77.7944
2025	10	8	7	0	30	29.52	95.2	7.8724	77.7944
2025	10	8	7	10	30	30.6	96.6	7.8724	80.4405
2025	10	8	7	20	30	30.31	96.8	7.8724	79.6467
2025	10	8	7	30	30	29.61	95	7.8724	78.059
2025	10	8	7	40	30	29.55	95.8	7.8724	77.7944
2025	10	8	7	50	30	28.96	93.8	7.8724	76.4714

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	8	8	0	30	30.09	96.5	7.8724	79.1175
2025	10	8	8	10	30	30.07	94	7.8785	79.4463
2025	10	8	8	20	30	28.75	93.4	7.8785	76.0036
2025	10	8	8	30	30	30.28	94.2	7.8785	79.9759
2025	10	8	8	40	30	28.81	91.6	7.8785	76.2684
2025	10	8	8	50	30	30.52	95.1	7.8785	80.5056
2025	10	8	9	0	30	29.31	94.9	7.8785	77.3277
2025	10	8	9	10	30	29.28	94.1	7.8846	77.3901
2025	10	8	9	20	30	30.76	95.8	7.8785	81.0351
2025	10	8	9	30	30	29.85	93.5	7.8846	78.9803
2025	10	8	9	40	30	30.93	95.2	7.8785	81.5647
2025	10	8	9	50	30	30.47	94	7.8846	80.5705
2025	10	8	10	0	30	28.44	95.7	7.8846	75.0047
2025	10	8	10	10	30	30.6	96.6	7.8846	80.5704
2025	10	8	10	20	30	29.17	96.1	7.8846	76.8599
2025	10	8	10	30	30	30.23	95.3	7.8846	79.7753
2025	10	8	10	40	30	30.02	96.9	7.8846	78.9802
2025	10	8	10	50	30	29.89	96.5	7.8846	78.7151
2025	10	8	11	0	30	29.81	95	7.8846	78.7151
2025	10	8	11	10	30	30.85	97.3	7.8846	81.1004
2025	10	8	11	20	30	28.61	97	7.8846	75.2696
2025	10	8	11	30	30	30.17	97.6	7.8846	79.2451
2025	10	8	11	40	30	29.24	95.7	7.8846	77.1248
2025	10	8	11	50	30	30.46	95.8	7.8846	80.3052
2025	10	8	12	0	30	30.7	94.7	7.8846	81.1002
2025	10	8	12	10	30	29.8	94.6	7.8846	78.7149
2025	10	8	12	20	30	29.47	97.8	7.8785	77.3273
2025	10	8	12	30	30	28.49	94.4	7.8785	75.2087
2025	10	8	12	40	30	29.63	95.4	7.8785	78.1217
2025	10	8	12	50	30	28.58	94.4	7.8663	75.3515
2025	10	8	13	0	30	29.22	95.1	7.8724	77.0001
2025	10	8	13	10	30	29.98	94.2	7.8724	79.1169
2025	10	8	13	20	30	29.04	95.5	7.8785	76.5327
2025	10	8	13	30	30	29.35	95.9	7.8785	77.3271
2025	10	8	13	40	30	29.11	94.9	7.8724	76.7355
2025	10	8	13	50	30	28.98	94.2	7.8724	76.4709
2025	10	8	14	0	30	29.59	94.5	7.8663	77.9954
2025	10	8	14	10	30	29.63	92.5	7.8724	78.3231
2025	10	8	14	20	30	29.61	94.8	7.8724	78.0585
2025	10	8	14	30	30	29.51	95.1	7.8663	77.731
2025	10	8	14	40	30	29.71	95	7.8785	78.3864
2025	10	8	14	50	30	28.96	93.8	7.8785	76.5327
2025	10	8	15	0	30	29.29	94.5	7.8785	77.3271
2025	10	8	15	10	30	28.97	96.1	7.8724	76.2063
2025	10	8	15	20	30	29.33	95.5	7.8724	77.2647
2025	10	8	15	30	30	29.03	95.3	7.8663	76.4091
2025	10	8	15	40	30	30.07	94	7.8663	79.3174
2025	10	8	15	50	30	29.4	94.7	7.8663	77.4666

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	8	16	0	30	29.6	96.6	7.8724	77.7939
2025	10	8	16	10	30	29.47	96.2	7.8724	77.5293
2025	10	8	16	20	30	30.61	94.9	7.8663	80.6394
2025	10	8	16	30	30	29.59	94.5	7.8602	77.9324
2025	10	8	16	40	30	29.13	92.8	7.8663	76.9379
2025	10	8	16	50	30	29.63	95.4	7.8724	78.0586
2025	10	8	17	0	30	29.57	93.9	7.8724	78.0586
2025	10	8	17	10	30	29.05	97.5	7.8602	76.0832
2025	10	8	17	20	30	29.84	95.6	7.8602	78.4608
2025	10	8	17	30	30	28.68	94.2	7.8663	75.6161
2025	10	8	17	40	30	29.43	95.5	7.8663	77.4668
2025	10	8	17	50	30	28.34	95.7	7.8724	74.6189
2025	10	8	18	0	30	29.63	92.5	7.8724	78.3234
2025	10	8	18	10	30	29	96.7	7.8663	76.1449
2025	10	8	18	20	30	29.91	95	7.8663	78.7889
2025	10	8	18	30	30	29.41	96.8	7.8602	77.1401
2025	10	8	18	40	30	29.3	94.7	7.8602	77.1401
2025	10	8	18	50	30	29.54	92.9	7.8663	77.9958
2025	10	8	19	0	30	29.65	93.5	7.8602	78.1969
2025	10	8	19	10	30	30.46	93.6	7.8663	80.3753
2025	10	8	19	20	30	30.18	96.3	7.8602	79.2536
2025	10	8	19	30	30	30.76	93.5	7.8602	81.1029
2025	10	8	19	40	30	30.65	97.3	7.8724	80.4404
2025	10	8	19	50	30	29.87	96.1	7.8663	78.5247
2025	10	8	20	0	30	30.39	96.4	7.8602	79.782
2025	10	8	20	10	30	29.69	94.4	7.8663	78.2603
2025	10	8	20	20	30	30.26	95.9	7.8602	79.5179
2025	10	8	20	30	30	30.26	93.6	7.8663	79.8467
2025	10	8	20	40	30	30.97	95.9	7.8663	81.433
2025	10	8	20	50	30	29.84	95.6	7.8602	78.4612
2025	10	8	21	0	30	29.23	95.5	7.8663	76.9384
2025	10	8	21	10	30	29.3	94.7	7.8602	77.1403
2025	10	8	21	20	30	30.88	94.1	7.8663	81.4331
2025	10	8	21	30	30	30.44	93	7.8602	80.3105
2025	10	8	21	40	30	30.32	95.1	7.8663	79.8467
2025	10	8	21	50	30	30.12	95.1	7.8602	79.2538
2025	10	8	22	0	30	30.48	94.1	7.8602	80.3105
2025	10	8	22	10	30	29.8	94.6	7.8602	78.4612
2025	10	8	22	20	30	29.61	94.8	7.8602	77.9329
2025	10	8	22	30	30	30.61	96.8	7.8602	80.3105
2025	10	8	22	40	30	29.57	96.2	7.8602	77.6687
2025	10	8	22	50	30	30.3	94.5	7.8602	79.7821
2025	10	8	23	0	30	30.55	95.6	7.8602	80.3105
2025	10	8	23	10	30	29.79	96.6	7.8663	78.2604
2025	10	8	23	20	30	30.48	96.2	7.8602	80.0463
2025	10	8	23	30	30	29.91	95	7.8663	78.7891
2025	10	8	23	40	30	29.54	95.6	7.8602	77.6687
2025	10	8	23	50	30	29.66	93.7	7.8602	78.197

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	9	0	0	30	30.15	95.7	7.8663	79.3179
2025	10	9	0	10	30	30.12	95.1	7.8663	79.3179
2025	10	9	0	20	30	29.97	94	7.8602	78.9895
2025	10	9	0	30	30	30.14	97.2	7.8602	78.9895
2025	10	9	0	40	30	29.91	95	7.8663	78.7891
2025	10	9	0	50	30	29.71	95	7.8602	78.197
2025	10	9	1	0	30	29.63	95.4	7.8663	77.9959
2025	10	9	1	10	30	30.82	95	7.8602	81.1029
2025	10	9	1	20	30	30.25	95.7	7.8663	79.5822
2025	10	9	1	30	30	29.43	97.2	7.8724	77.2651
2025	10	9	1	40	30	28.98	94.4	7.8602	76.3476
2025	10	9	1	50	30	29.56	97.6	7.8663	77.467
2025	10	9	2	0	30	30.87	93.9	7.8602	81.367
2025	10	9	2	10	30	29.12	95.1	7.8602	76.6118
2025	10	9	2	20	30	29.71	95	7.8602	78.1969
2025	10	9	2	30	30	30.43	95.3	7.8724	80.1757
2025	10	9	2	40	30	30.54	92.8	7.8602	80.5744
2025	10	9	2	50	30	29.76	93.7	7.8602	78.461
2025	10	9	3	0	30	29.78	96.4	7.8663	78.2601
2025	10	9	3	10	30	29.84	95.6	7.8724	78.5881
2025	10	9	3	20	30	30.89	96.3	7.8724	81.2341
2025	10	9	3	30	30	29.6	96.6	7.8663	77.7313
2025	10	9	3	40	30	30.34	95.5	7.8602	79.7819
2025	10	9	3	50	30	28.76	93.6	7.8663	75.8806
2025	10	9	4	0	30	29.75	95.8	7.8663	78.2601
2025	10	9	4	10	30	29.08	96.3	7.8541	76.2857
2025	10	9	4	20	30	29.04	93	7.8541	76.5497
2025	10	9	4	30	30	29.28	94.1	7.8602	77.1401
2025	10	9	4	40	30	30.43	95.3	7.8541	79.9812
2025	10	9	4	50	30	30.19	96.5	7.8663	79.3176
2025	10	9	5	0	30	30.19	96.5	7.8724	79.3818
2025	10	9	5	10	30	29.36	93.5	7.8724	77.5296
2025	10	9	5	20	30	29.78	96.4	7.8724	78.3234
2025	10	9	5	30	30	30.6	94.7	7.8724	80.7048
2025	10	9	5	40	30	29.74	95.6	7.8724	78.3234
2025	10	9	5	50	30	30.87	96	7.8724	81.2341
2025	10	9	6	0	30	30.84	97.1	7.8724	80.9695
2025	10	9	6	10	30	30.7	94.7	7.8724	80.9695
2025	10	9	6	20	30	30.16	95.9	7.8724	79.3818
2025	10	9	6	30	30	30.9	94.6	7.8724	81.4987
2025	10	9	6	40	30	30.45	97.4	7.8724	79.911
2025	10	9	6	50	30	30.07	96.1	7.8724	79.1172
2025	10	9	7	0	30	29.96	95.9	7.8724	78.8526
2025	10	9	7	10	30	30.34	95.5	7.8724	79.9111
2025	10	9	7	20	30	29.78	96.4	7.8724	78.3234
2025	10	9	7	30	30	30.21	94.9	7.8724	79.6465
2025	10	9	7	40	30	29.2	94.7	7.8724	77.0004
2025	10	9	7	50	30	30.31	96.8	7.8724	79.6465

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	9	8	0	30	30.17	94	7.8724	79.6465
2025	10	9	8	10	30	29.28	96.3	7.8663	76.9382
2025	10	9	8	20	30	28.45	93.4	7.8663	75.0874
2025	10	9	8	30	30	29.07	93.9	7.8602	76.6118
2025	10	9	8	40	30	30.25	93.2	7.8663	79.8465
2025	10	9	8	50	30	29.55	93.5	7.8541	77.8695
2025	10	9	9	0	30	29.57	93.9	7.8602	77.9326
2025	10	9	9	10	30	29.02	97.1	7.8541	76.0218
2025	10	9	9	20	30	30.31	94.9	7.8724	79.911
2025	10	9	9	30	30	30.15	95.7	7.8663	79.3177
2025	10	9	9	40	30	29.47	94.1	7.8663	77.7313
2025	10	9	9	50	30	29.28	94.1	7.8663	77.2025
2025	10	9	10	0	30	29.03	95.3	7.8663	76.4093
2025	10	9	10	10	30	29.39	94.5	7.8663	77.4669
2025	10	9	10	20	30	28.92	95.2	7.8541	76.0217
2025	10	9	10	30	30	29.27	93.9	7.8602	77.14
2025	10	9	10	40	30	28.72	95.2	7.8724	75.6772
2025	10	9	10	50	30	29.77	94	7.8663	78.5243
2025	10	9	11	0	30	29.71	95	7.8602	78.1966
2025	10	9	11	10	30	28.88	94.2	7.8602	76.0832
2025	10	9	11	20	30	29.36	93.7	7.8602	77.404
2025	10	9	11	30	30	28.86	93.8	7.8663	76.1447
2025	10	9	11	40	30	28.92	95.2	7.8663	76.1447
2025	10	9	11	50	30	30.04	97.3	7.8663	78.7886
2025	10	9	12	0	30	29.72	91.9	7.8602	78.4606
2025	10	9	12	10	30	29.87	94	7.8663	78.7886
2025	10	9	12	20	30	29.61	94.8	7.8724	78.0585
2025	10	9	12	30	30	29.54	95.6	7.8602	77.6681
2025	10	9	12	40	30	29.32	92	7.8602	77.4039
2025	10	9	12	50	30	30.11	95	7.8663	79.3173
2025	10	9	13	0	30	28.9	96.8	7.8541	75.7574
2025	10	9	13	10	30	28.93	92.8	7.8663	76.409
2025	10	9	13	20	30	28.73	95.4	7.8541	75.4934
2025	10	9	13	30	30	29.05	93.4	7.8541	76.5493
2025	10	9	13	40	30	29.42	95.3	7.8419	77.2158
2025	10	9	13	50	30	29.4	94.7	7.848	77.2785
2025	10	9	14	0	30	29.15	95.9	7.8541	76.5493
2025	10	9	14	10	30	29.5	96.6	7.8541	77.3412
2025	10	9	14	20	30	29.08	94.1	7.8541	76.5493
2025	10	9	14	30	30	28.6	94.8	7.8602	75.2904
2025	10	9	14	40	30	28.23	92.4	7.8541	74.4376
2025	10	9	14	50	30	29.28	94.1	7.848	77.0147
2025	10	9	15	0	30	30.44	93	7.8541	80.2448
2025	10	9	15	10	30	29.31	94.9	7.8419	76.9523
2025	10	9	15	20	30	29.42	95.1	7.8419	77.2158
2025	10	9	15	30	30	29.66	93.7	7.848	78.0697
2025	10	9	15	40	30	29.33	92.5	7.8419	77.2158
2025	10	9	15	50	30	28.88	94.2	7.848	75.9598

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	9	16	0	30	28.46	96.1	7.8358	74.52
2025	10	9	16	10	30	29.47	94.1	7.8358	77.4165
2025	10	9	16	20	30	29.31	96.9	7.848	76.751
2025	10	9	16	30	30	29.7	94.6	7.8358	77.9432
2025	10	9	16	40	30	29.55	93.5	7.8358	77.6798
2025	10	9	16	50	30	28.75	93.4	7.8419	75.6347
2025	10	9	17	0	30	28.92	95.2	7.8358	75.8366
2025	10	9	17	10	30	29.32	95.1	7.8419	76.9524
2025	10	9	17	20	30	29.87	93.8	7.8419	78.5336
2025	10	9	17	30	30	29.91	95	7.8358	78.4699
2025	10	9	17	40	30	28.68	94.2	7.8419	75.3712
2025	10	9	17	50	30	30.41	94.9	7.8236	79.6569
2025	10	9	18	0	30	29.45	95.8	7.8419	77.216
2025	10	9	18	10	30	28.58	94.4	7.8297	74.9858
2025	10	9	18	20	30	29.27	93.9	7.8297	76.8275
2025	10	9	18	30	30	30.13	95.3	7.8358	78.9966
2025	10	9	18	40	30	29.38	94.1	7.8297	77.0907
2025	10	9	18	50	30	29.42	97	7.8358	76.89
2025	10	9	19	0	30	29.86	96	7.8297	78.1431
2025	10	9	19	10	30	29.36	93.5	7.8297	77.0907
2025	10	9	19	20	30	29.24	95.7	7.8297	76.5645
2025	10	9	19	30	30	30.31	94.9	7.8358	79.5233
2025	10	9	19	40	30	30.03	92.5	7.8358	78.9966
2025	10	9	19	50	30	30.01	95	7.8297	78.6694
2025	10	9	20	0	30	30.18	94.2	7.8358	79.26
2025	10	9	20	10	30	28.49	94.4	7.8297	74.7227
2025	10	9	20	20	30	29.59	94.5	7.8358	77.68
2025	10	9	20	30	30	28.12	95.3	7.8297	73.6703
2025	10	9	20	40	30	29.03	95.3	7.8297	76.0383
2025	10	9	20	50	30	28.92	95.2	7.8236	75.7136
2025	10	9	21	0	30	29.03	95.3	7.8297	76.0383
2025	10	9	21	10	30	28.84	93.2	7.8297	75.7752
2025	10	9	21	20	30	28.87	94	7.8236	75.7136
2025	10	9	21	30	30	30.52	95.1	7.8175	79.8549
2025	10	9	21	40	30	29.13	95.5	7.8297	76.3014
2025	10	9	21	50	30	29.67	94.1	7.8236	77.8168
2025	10	9	22	0	30	29.16	93.5	7.8297	76.5646
2025	10	9	22	10	30	29.87	94	7.8358	78.4701
2025	10	9	22	20	30	29.32	95.3	7.8175	76.7027
2025	10	9	22	30	30	29.59	94.5	7.8236	77.5539
2025	10	9	22	40	30	29.13	92.6	7.8236	76.5023
2025	10	9	22	50	30	28.96	95.9	7.8297	75.7752
2025	10	9	23	0	30	28.86	93.6	7.8297	75.7752
2025	10	9	23	10	30	28.43	95.4	7.8236	74.3991
2025	10	9	23	20	30	30.39	94.3	7.8236	79.657
2025	10	9	23	30	30	29.34	95.7	7.8236	76.7651
2025	10	9	23	40	30	30.1	94.8	7.8175	78.8041
2025	10	9	23	50	30	29.46	93.7	7.8236	77.2909

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	10	0	0	30	29.95	95.7	7.8236	78.3425
2025	10	10	0	10	30	29.45	95.8	7.8236	77.028
2025	10	10	0	20	30	29.34	93.1	7.8175	76.9653
2025	10	10	0	30	30	29.06	95.9	7.8236	75.9764
2025	10	10	0	40	30	30.33	97	7.8297	79.1955
2025	10	10	0	50	30	29.71	95	7.8236	77.8166
2025	10	10	1	0	30	29.24	95.7	7.8236	76.5021
2025	10	10	1	10	30	30	98	7.8236	78.0795
2025	10	10	1	20	30	29.95	95.7	7.8236	78.3424
2025	10	10	1	30	30	29.11	94.9	7.8236	76.2392
2025	10	10	1	40	30	29.91	95	7.8236	78.3423
2025	10	10	1	50	30	28.98	94.4	7.8236	75.9763
2025	10	10	2	0	30	29.47	94.1	7.8236	77.2907
2025	10	10	2	10	30	29.95	95.7	7.8236	78.3423
2025	10	10	2	20	30	29.98	96.3	7.8236	78.3423
2025	10	10	2	30	30	29.15	95.9	7.8236	76.2391
2025	10	10	2	40	30	29.95	95.7	7.8236	78.3422
2025	10	10	2	50	30	29.57	94.1	7.8236	77.5535
2025	10	10	3	0	30	29.07	96.1	7.8175	75.9144
2025	10	10	3	10	30	29.77	93.9	7.8236	78.0793
2025	10	10	3	20	30	30.05	97.5	7.8236	78.3422
2025	10	10	3	30	30	29.2	94.7	7.8236	76.5019
2025	10	10	3	40	30	29.47	94.1	7.8236	77.2906
2025	10	10	3	50	30	28.88	94.2	7.8236	75.7132
2025	10	10	4	0	30	29.24	95.7	7.8236	76.5019
2025	10	10	4	10	30	29.19	96.5	7.8175	76.177
2025	10	10	4	20	30	28.69	94.6	7.8175	75.1262
2025	10	10	4	30	30	29.44	95.7	7.8175	76.965
2025	10	10	4	40	30	29.13	95.5	7.8175	76.1769
2025	10	10	4	50	30	29.36	96.1	7.8175	76.7023
2025	10	10	5	0	30	30	94.8	7.8236	78.605
2025	10	10	5	10	30	30.05	97.5	7.8175	78.2784
2025	10	10	5	20	30	29.75	95.8	7.8236	77.8163
2025	10	10	5	30	30	29.09	94.5	7.8236	76.2389
2025	10	10	5	40	30	29.63	97.2	7.8236	77.2905
2025	10	10	5	50	30	29.72	95.2	7.8236	77.8163
2025	10	10	6	0	30	29.42	95.3	7.8236	77.0276
2025	10	10	6	10	30	29.53	95.4	7.8175	77.2276
2025	10	10	6	20	30	29.99	96.5	7.8236	78.3421
2025	10	10	6	30	30	29.5	94.7	7.8236	77.2905
2025	10	10	6	40	30	30.38	96.2	7.8358	79.5228
2025	10	10	6	50	30	28.95	95.7	7.8236	75.7131
2025	10	10	7	0	30	30.13	95.3	7.8236	78.8678
2025	10	10	7	10	30	28.64	95.6	7.8297	74.9854
2025	10	10	7	20	30	29.47	93.9	7.8297	77.3533
2025	10	10	7	30	30	29.96	95.9	7.8297	78.4058
2025	10	10	7	40	30	29.64	97.4	7.8358	77.4162
2025	10	10	7	50	30	28.84	95.6	7.8236	75.4502

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	10	8	0	30	29.01	94.9	7.8236	75.976
2025	10	10	8	10	30	29.55	95.8	7.8236	77.2905
2025	10	10	8	20	30	29.38	94.1	7.8236	77.0276
2025	10	10	8	30	30	29.4	94.7	7.8297	77.0902
2025	10	10	8	40	30	29.81	95	7.8297	78.1426
2025	10	10	8	50	30	28.81	95	7.8175	75.3888
2025	10	10	9	0	30	28.99	94.6	7.8175	75.9141
2025	10	10	9	10	30	29.1	98.3	7.8358	75.8362
2025	10	10	9	20	30	28.99	94.6	7.8297	76.0377
2025	10	10	9	30	30	30.1	96.7	7.8297	78.6687
2025	10	10	9	40	30	29.7	96.6	7.8358	77.6794
2025	10	10	9	50	30	29.21	94.9	7.8297	76.5638
2025	10	10	10	0	30	28.26	93.7	7.8236	74.1355
2025	10	10	10	10	30	29.28	94.1	7.8175	76.702
2025	10	10	10	20	30	29.86	96	7.8297	78.1424
2025	10	10	10	30	30	29.19	94.5	7.8297	76.5637
2025	10	10	10	40	30	28.58	94.2	7.8175	74.8632
2025	10	10	10	50	30	29.32	95.1	7.8236	76.7643
2025	10	10	11	0	30	28.97	96.1	7.8297	75.7743
2025	10	10	11	10	30	28.47	94	7.8297	74.7219
2025	10	10	11	20	30	29.36	96.1	7.8297	76.8267
2025	10	10	11	30	30	28.88	94.2	7.8236	75.7127
2025	10	10	11	40	30	29.92	96.9	7.8236	78.0786
2025	10	10	11	50	30	29.1	94.7	7.8236	76.2384
2025	10	10	12	0	30	29.95	95.7	7.8175	78.2777
2025	10	10	12	10	30	29.73	95.4	7.8175	77.7524
2025	10	10	12	20	30	29.29	96.5	7.8236	76.5012
2025	10	10	12	30	30	28.86	93.6	7.8236	75.7125
2025	10	10	12	40	30	29.08	94.3	7.8236	76.2383
2025	10	10	12	50	30	28.68	94.4	7.8236	75.1867
2025	10	10	13	0	30	28.78	94.4	7.8175	75.3882
2025	10	10	13	10	30	29.6	94.7	7.8175	77.4896
2025	10	10	13	20	30	29.01	94.9	7.8114	75.8517
2025	10	10	13	30	30	29.48	94.3	7.8175	77.2268
2025	10	10	13	40	30	29.25	95.9	7.8236	76.501
2025	10	10	13	50	30	29.8	94.6	7.8114	77.9513
2025	10	10	14	0	30	29.41	94.9	7.8236	77.0268
2025	10	10	14	10	30	29.13	92.6	7.8175	76.4388
2025	10	10	14	20	30	28.49	94.4	7.8175	74.6
2025	10	10	14	30	30	29.28	94.1	7.8114	76.6389
2025	10	10	14	40	30	29.21	94.9	7.8114	76.3765
2025	10	10	14	50	30	29.9	94.6	7.8175	78.2775
2025	10	10	15	0	30	28.76	96	7.8114	75.0641
2025	10	10	15	10	30	29.75	95.8	7.8114	77.6888
2025	10	10	15	20	30	28.93	92.8	7.8053	75.7897
2025	10	10	15	30	30	28.96	93.6	7.8114	75.8515
2025	10	10	15	40	30	29.03	92.6	7.8175	76.176
2025	10	10	15	50	30	28.95	95.7	7.8175	75.6507

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	10	16	0	30	28.93	92.8	7.8053	75.7897
2025	10	10	16	10	30	30.33	95.3	7.8053	79.1989
2025	10	10	16	20	30	29.08	97.9	7.8114	75.589
2025	10	10	16	30	30	29.04	93.2	7.8175	76.176
2025	10	10	16	40	30	28.96	93.6	7.7992	75.7279
2025	10	10	16	50	30	29.58	94.3	7.8114	77.4263
2025	10	10	17	0	30	28.76	93.8	7.8053	75.2652
2025	10	10	17	10	30	30.25	93.2	7.8175	79.3281
2025	10	10	17	20	30	28.62	95.2	7.8114	74.8017
2025	10	10	17	30	30	29.99	94.4	7.8053	78.4122
2025	10	10	17	40	30	28.7	96.8	7.8053	74.7408
2025	10	10	17	50	30	30.23	97	7.8114	78.7386
2025	10	10	18	0	30	28.78	94.4	7.8053	75.2653
2025	10	10	18	10	30	30.6	94.7	7.8053	79.9858
2025	10	10	18	20	30	29.8	94.6	7.8053	77.8878
2025	10	10	18	30	30	30.24	95.5	7.8114	79.0011
2025	10	10	18	40	30	30.11	95	7.8175	78.8029
2025	10	10	18	50	30	29.88	96.3	7.8114	77.9513
2025	10	10	19	0	30	30.38	94.2	7.8114	79.5261
2025	10	10	19	10	30	30.11	95	7.8053	78.6746
2025	10	10	19	20	30	29.42	95.3	7.8053	76.8389
2025	10	10	19	30	30	29.62	95.2	7.8053	77.3633
2025	10	10	19	40	30	30.12	96.9	7.8053	78.4124
2025	10	10	19	50	30	28.68	94.4	7.8053	75.0031
2025	10	10	20	0	30	30.55	95.6	7.8053	79.7236
2025	10	10	20	10	30	29.29	94.5	7.8053	76.5766
2025	10	10	20	20	30	29.92	95.2	7.7992	78.0864
2025	10	10	20	30	30	30.36	95.9	7.7931	79.07
2025	10	10	20	40	30	29.64	95.6	7.8053	77.3634
2025	10	10	20	50	30	29.88	97.9	7.8053	77.6257
2025	10	10	21	0	30	30.06	95.9	7.7992	78.3485
2025	10	10	21	10	30	29.18	96.3	7.8053	76.0522
2025	10	10	21	20	30	29.37	96.3	7.7992	76.5142
2025	10	10	21	30	30	30.27	96.1	7.7992	78.8725
2025	10	10	21	40	30	29.72	92.3	7.8053	77.8879
2025	10	10	21	50	30	29.44	95.7	7.7992	76.7763
2025	10	10	22	0	30	29.14	93	7.8053	76.3144
2025	10	10	22	10	30	29.13	95.3	7.7992	75.9902
2025	10	10	22	20	30	29.88	94.2	7.8053	78.1502
2025	10	10	22	30	30	28.88	94.4	7.8053	75.5277
2025	10	10	22	40	30	29.82	96.9	7.8053	77.6257
2025	10	10	22	50	30	30.17	96.1	7.8053	78.6747
2025	10	10	23	0	30	28.79	94.6	7.8053	75.2654
2025	10	10	23	10	30	29.91	95	7.8053	78.1502
2025	10	10	23	20	30	30.45	95.7	7.8053	79.4614
2025	10	10	23	30	30	29.82	96.9	7.8053	77.6257
2025	10	10	23	40	30	28.82	95.2	7.7992	75.204
2025	10	10	23	50	30	29.18	96.3	7.7992	75.9901

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	11	0	0	30	28.9	94.8	7.7992	75.4661
2025	10	11	0	10	30	28.83	95.4	7.7931	75.1426
2025	10	11	0	20	30	29.41	94.9	7.8053	76.8389
2025	10	11	0	30	30	30.01	95	7.8053	78.4124
2025	10	11	0	40	30	29.53	95.4	7.7992	77.0383
2025	10	11	0	50	30	29.81	95	7.8114	77.9514
2025	10	11	1	0	30	30.31	96.8	7.8053	78.9369
2025	10	11	1	10	30	29.81	95	7.8053	77.8879
2025	10	11	1	20	30	28.93	95.4	7.8053	75.5276
2025	10	11	1	30	30	29.56	96	7.8053	77.1011
2025	10	11	1	40	30	29.51	95.1	7.8053	77.1011
2025	10	11	1	50	30	28.92	95.2	7.8053	75.5276
2025	10	11	2	0	30	30.44	95.5	7.8114	79.5261
2025	10	11	2	10	30	30.47	96	7.8175	79.5909
2025	10	11	2	20	30	29.64	95.6	7.8175	77.4895
2025	10	11	2	30	30	29.47	96.2	7.8114	76.9015
2025	10	11	2	40	30	29.6	94.7	7.8053	77.3633
2025	10	11	2	50	30	29.25	95.9	7.8053	76.3143
2025	10	11	3	0	30	30.01	98.2	7.8053	77.8878
2025	10	11	3	10	30	28.54	93.2	7.7992	74.6798
2025	10	11	3	20	30	29.04	95.5	7.7992	75.728
2025	10	11	3	30	30	29.55	93.3	7.8053	77.3633
2025	10	11	3	40	30	29.85	95.8	7.7992	77.8242
2025	10	11	3	50	30	30.27	96.1	7.7992	78.8724
2025	10	11	4	0	30	28.62	95.2	7.7931	74.6189
2025	10	11	4	10	30	29.38	94.3	7.7992	76.7761
2025	10	11	4	20	30	30.47	96	7.7992	79.3964
2025	10	11	4	30	30	30.27	96.1	7.7992	78.8724
2025	10	11	4	40	30	29.92	96.9	7.8175	78.0148
2025	10	11	4	50	30	30.56	93.6	7.8114	80.0509
2025	10	11	5	0	30	29.71	94.8	7.8114	77.6888
2025	10	11	5	10	30	30.71	94.9	7.8114	80.3134
2025	10	11	5	20	30	29.37	93.9	7.8114	76.9014
2025	10	11	5	30	30	29.08	94.3	7.8053	76.052
2025	10	11	5	40	30	29.81	95	7.8114	77.9513
2025	10	11	5	50	30	29.75	95.8	7.8114	77.6888
2025	10	11	6	0	30	30.55	95.6	7.8053	79.7235
2025	10	11	6	10	30	29.01	94.9	7.7992	75.728
2025	10	11	6	20	30	29.75	93.5	7.7992	77.8243
2025	10	11	6	30	30	31.31	94.8	7.7992	81.7548
2025	10	11	6	40	30	28.9	96.8	7.7992	75.204
2025	10	11	6	50	30	29.17	93.9	7.8053	76.3143
2025	10	11	7	0	30	29.62	97	7.8053	77.1011
2025	10	11	7	10	30	30.81	94.8	7.8053	80.5104
2025	10	11	7	20	30	27.57	94.2	7.8053	72.1184
2025	10	11	7	30	30	29.18	96.3	7.8053	76.0521
2025	10	11	7	40	30	29.14	95.7	7.7992	75.9901
2025	10	11	7	50	30	29.62	95.2	7.8053	77.3634

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	11	8	0	30	29.88	96.3	7.7992	77.8244
2025	10	11	8	10	30	29.35	95.9	7.8053	76.5767
2025	10	11	8	20	30	29.85	95.8	7.7931	77.7609
2025	10	11	8	30	30	29.56	93.7	7.8053	77.3634
2025	10	11	8	40	30	30.27	93.8	7.7931	79.07
2025	10	11	8	50	30	30.44	95.5	7.7931	79.3318
2025	10	11	9	0	30	29.46	93.5	7.7931	76.9754
2025	10	11	9	10	30	29.55	95.8	7.7931	76.9754
2025	10	11	9	20	30	30.86	95.8	7.787	80.3134
2025	10	11	9	30	30	29.88	96.3	7.787	77.6973
2025	10	11	9	40	30	31.04	95.4	7.787	80.8366
2025	10	11	9	50	30	29.88	96.3	7.787	77.6973
2025	10	11	10	0	30	30.23	95.3	7.787	78.7437
2025	10	11	10	10	30	28.65	93.4	7.787	74.8196
2025	10	11	10	20	30	28.97	96.1	7.787	75.3428
2025	10	11	10	30	30	28.46	93.6	7.787	74.2963
2025	10	11	10	40	30	30.17	96.1	7.787	78.482
2025	10	11	10	50	30	29.12	95.1	7.7809	75.8039
2025	10	11	11	0	30	30.26	95.9	7.787	78.7436
2025	10	11	11	10	30	29.56	96	7.7809	76.8495
2025	10	11	11	20	30	28.96	93.8	7.7809	75.5425
2025	10	11	11	30	30	29.08	94.1	7.7809	75.8039
2025	10	11	11	40	30	28.96	95.9	7.787	75.3427
2025	10	11	11	50	30	28.23	95.5	7.7809	73.4513
2025	10	11	12	0	30	29.25	95.9	7.7809	76.0652
2025	10	11	12	10	30	29.34	95.7	7.7809	76.3266
2025	10	11	12	20	30	29.43	95.5	7.7748	76.5253
2025	10	11	12	30	30	29.46	97.6	7.7748	76.2641
2025	10	11	12	40	30	29.42	95.3	7.7809	76.5879
2025	10	11	12	50	30	28.92	95.2	7.7748	75.2194
2025	10	11	13	0	30	28.69	94.6	7.7687	74.6358
2025	10	11	13	10	30	29.25	95.9	7.7687	75.9407
2025	10	11	13	20	30	29.64	95.6	7.7748	77.0476
2025	10	11	13	30	30	28.33	92.4	7.7687	73.8529
2025	10	11	13	40	30	28.89	94.6	7.7687	75.1578
2025	10	11	13	50	30	28.23	95.5	7.7626	73.2709
2025	10	11	14	0	30	29.69	94.4	7.7565	77.1189
2025	10	11	14	10	30	30.4	96.6	7.7565	78.6822
2025	10	11	14	20	30	29.32	95.3	7.7565	76.0768
2025	10	11	14	30	30	28.32	95.3	7.7505	73.4112
2025	10	11	14	40	30	29.42	95.3	7.7505	76.2747
2025	10	11	14	50	30	27.77	93.9	7.7565	72.1688
2025	10	11	15	0	30	28.73	95.4	7.7565	74.5136
2025	10	11	15	10	30	28.56	93.6	7.7505	74.1921
2025	10	11	15	20	30	29.06	95.9	7.7505	75.2334
2025	10	11	15	30	30	28.21	95.1	7.7444	73.0908
2025	10	11	15	40	30	29.16	93.5	7.7383	75.6296
2025	10	11	15	50	30	29.14	93	7.7383	75.6297

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	11	16	0	30	28.85	93.4	7.7322	74.7884
2025	10	11	16	10	30	29.23	95.5	7.7322	75.5675
2025	10	11	16	20	30	29.51	95.1	7.7261	76.2837
2025	10	11	16	30	30	30.64	95.4	7.7261	79.1379
2025	10	11	16	40	30	28.49	94.4	7.72	73.6283
2025	10	11	16	50	30	29.04	95.5	7.72	74.9246
2025	10	11	17	0	30	29.2	96.7	7.7139	75.1219
2025	10	11	17	10	30	30.56	95.8	7.7139	78.7485
2025	10	11	17	20	30	29.15	95.9	7.7078	75.06
2025	10	11	17	30	30	28.39	94.6	7.7078	73.2482
2025	10	11	17	40	30	29.35	93.3	7.7078	75.8365
2025	10	11	17	50	30	28.04	95.7	7.7017	72.1533
2025	10	11	18	0	30	28.54	95.6	7.7017	73.4464
2025	10	11	18	10	30	28.73	95.4	7.7017	73.9636
2025	10	11	18	20	30	28.38	94.2	7.7017	73.1878
2025	10	11	18	30	30	28.63	95.4	7.7017	73.7051
2025	10	11	18	40	30	29.56	93.7	7.6956	76.2282
2025	10	11	18	50	30	28.81	95	7.6956	74.161
2025	10	11	19	0	30	29.79	94.4	7.6956	76.745
2025	10	11	19	10	30	28.98	94.2	7.6895	74.6161
2025	10	11	19	20	30	28.43	95.4	7.6956	73.1274
2025	10	11	19	30	30	29.58	96.4	7.6895	75.907
2025	10	11	19	40	30	28.4	94.8	7.6895	73.067
2025	10	11	19	50	30	28.67	94	7.6895	73.8416
2025	10	11	20	0	30	29.13	95.3	7.6895	74.8744
2025	10	11	20	10	30	29.62	95.2	7.6895	76.1653
2025	10	11	20	20	30	29.47	94.1	7.6834	75.8443
2025	10	11	20	30	30	27.68	94.4	7.6834	71.2008
2025	10	11	20	40	30	28.49	94.6	7.6834	73.2646
2025	10	11	20	50	30	28.16	96.1	7.6834	72.2327
2025	10	11	21	0	30	28.99	94.6	7.6834	74.5545
2025	10	11	21	10	30	28.74	97.4	7.6834	73.5227
2025	10	11	21	20	30	30.05	95.7	7.6834	77.1343
2025	10	11	21	30	30	29.25	95.9	7.6834	75.0705
2025	10	11	21	40	30	29.13	95.3	7.6773	74.7506
2025	10	11	21	50	30	27.45	96.1	7.6773	70.3686
2025	10	11	22	0	30	28.38	98.1	7.6773	72.4307
2025	10	11	22	10	30	29.19	96.5	7.6773	74.7506
2025	10	11	22	20	30	29.72	95.2	7.6773	76.2972
2025	10	11	22	30	30	29.81	95	7.6773	76.5549
2025	10	11	22	40	30	29.86	96	7.6712	76.4914
2025	10	11	22	50	30	29.55	95.8	7.6712	75.7188
2025	10	11	23	0	30	28.06	93.9	7.6712	72.1132
2025	10	11	23	10	30	29.53	95.4	7.6712	75.7188
2025	10	11	23	20	30	28.49	94.6	7.6651	73.0826
2025	10	11	23	30	30	28.77	96.2	7.6651	73.5973
2025	10	11	23	40	30	29.88	96.3	7.6651	76.428
2025	10	11	23	50	30	29.08	96.3	7.6651	74.3693

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	12	0	0	30	29.57	96.2	7.659	75.5932
2025	10	12	0	10	30	28.81	95	7.659	73.7933
2025	10	12	0	20	30	28.6	94.8	7.659	73.2791
2025	10	12	0	30	30	28.87	96.2	7.6529	73.732
2025	10	12	0	40	30	28.5	96.9	7.6529	72.7044
2025	10	12	0	50	30	27.74	95.8	7.6468	70.8471
2025	10	12	1	0	30	29.12	95.1	7.6346	74.3168
2025	10	12	1	10	30	27.8	94.7	7.6346	70.9853
2025	10	12	1	20	30	27.28	94.4	7.6285	69.6459
2025	10	12	1	30	30	28.13	92.9	7.6285	71.9503
2025	10	12	1	40	30	27.27	96.3	7.6285	69.3898
2025	10	12	1	50	30	28.21	91.8	7.6285	72.2064
2025	10	12	2	0	30	29.04	93.2	7.6285	74.2548
2025	10	12	2	10	30	28.84	95.6	7.6224	73.4253
2025	10	12	2	20	30	28.04	95.7	7.6224	71.3786
2025	10	12	2	30	30	29.52	95.2	7.6224	75.2162
2025	10	12	2	40	30	29.28	96.3	7.6224	74.4487
2025	10	12	2	50	30	28.1	94.9	7.6163	71.5747
2025	10	12	3	0	30	26.11	95.3	7.6163	66.4622
2025	10	12	3	10	30	28	98.4	7.6163	70.8078
2025	10	12	3	20	30	29.12	95.1	7.6163	74.1309
2025	10	12	3	30	30	28.51	95	7.6163	72.5972
2025	10	12	3	40	30	29.01	96.9	7.6163	73.6197
2025	10	12	3	50	30	27.27	94	7.6163	69.5297
2025	10	12	4	0	30	27.96	93.7	7.6102	71.2595
2025	10	12	4	10	30	29.22	95.1	7.6102	74.3244
2025	10	12	4	20	30	28.59	96.6	7.6102	72.5365
2025	10	12	4	30	30	28.92	95.2	7.6102	73.5582
2025	10	12	4	40	30	28.37	96.3	7.6102	72.0257
2025	10	12	4	50	30	29.18	94.3	7.6041	74.2623
2025	10	12	5	0	30	27.99	94.5	7.6041	71.1999
2025	10	12	5	10	30	29.08	94.1	7.6041	74.0071
2025	10	12	5	20	30	28.4	94.8	7.6041	72.2207
2025	10	12	5	30	30	27.62	95.4	7.6041	70.1792
2025	10	12	5	40	30	29.01	94.9	7.6041	73.7519
2025	10	12	5	50	30	28.1	94.9	7.6041	71.4552
2025	10	12	6	0	30	29.01	94.9	7.6041	73.7519
2025	10	12	6	10	30	29.31	96.9	7.5981	74.2002
2025	10	12	6	20	30	27.21	95.1	7.5981	69.1005
2025	10	12	6	30	30	27.19	94.6	7.5981	69.1005
2025	10	12	6	40	30	27.9	94.9	7.5981	70.8854
2025	10	12	6	50	30	29.11	96.9	7.5981	73.6903
2025	10	12	7	0	30	28.62	95.2	7.592	72.6094
2025	10	12	7	10	30	27.66	93.7	7.592	70.3165
2025	10	12	7	20	30	28.5	94.8	7.592	72.3547
2025	10	12	7	30	30	29.29	94.5	7.592	74.3928
2025	10	12	7	40	30	27.35	93.4	7.592	69.5522
2025	10	12	7	50	30	28.7	94.8	7.5859	72.8031

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	12	8	0	30	29.42	95.1	7.5859	74.585
2025	10	12	8	10	30	28.56	96	7.5859	72.294
2025	10	12	8	20	30	27.52	95.4	7.5859	69.7485
2025	10	12	8	30	30	27.34	95.9	7.5859	69.2394
2025	10	12	8	40	30	29.34	93.1	7.5859	74.5851
2025	10	12	8	50	30	27.67	93.9	7.5859	70.2576
2025	10	12	9	0	30	28.7	96.8	7.5859	72.5486
2025	10	12	9	10	30	28.79	94.6	7.5798	72.9963
2025	10	12	9	20	30	27.19	94.6	7.5798	68.9268
2025	10	12	9	30	30	29.1	96.7	7.5798	73.505
2025	10	12	9	40	30	27.23	97.4	7.5737	68.6148
2025	10	12	9	50	30	28.35	93.2	7.5737	71.9184
2025	10	12	10	0	30	28.77	96.2	7.5615	72.5586
2025	10	12	10	10	30	28.17	96.3	7.5615	71.0364
2025	10	12	10	20	30	27.19	94.6	7.5615	68.753
2025	10	12	10	30	30	27.87	96.4	7.5554	70.216
2025	10	12	10	40	30	29.35	95.9	7.5554	74.0183
2025	10	12	10	50	30	27.73	95.6	7.5554	69.9625
2025	10	12	11	0	30	27.48	98.2	7.5554	68.9486
2025	10	12	11	10	30	28.25	95.9	7.5554	71.23
2025	10	12	11	20	30	28.98	96.3	7.5493	72.9428
2025	10	12	11	30	30	30.65	97.3	7.5493	76.9951
2025	10	12	11	40	30	27.58	94.4	7.5493	69.6502
2025	10	12	11	50	30	30.1	94.8	7.5493	75.982
2025	10	12	12	0	30	28.49	94.6	7.5493	71.9296
2025	10	12	12	10	30	28.29	94.5	7.5493	71.4231
2025	10	12	12	20	30	29.15	95.9	7.5493	73.4492
2025	10	12	12	30	30	28.78	94.4	7.5493	72.6894
2025	10	12	12	40	30	29.17	96.1	7.5432	73.3873
2025	10	12	12	50	30	27.77	96.4	7.5432	69.8444
2025	10	12	13	0	30	28.89	96.6	7.5432	72.6281
2025	10	12	13	10	30	28.13	95.5	7.5432	70.8566
2025	10	12	13	20	30	27.54	95.8	7.5432	69.3383
2025	10	12	13	30	30	28.53	95.4	7.5432	71.8689
2025	10	12	13	40	30	29.78	97.9	7.5432	74.6525
2025	10	12	13	50	30	28.52	95.2	7.5432	71.8689
2025	10	12	14	0	30	27.55	97.7	7.5432	69.0852
2025	10	12	14	10	30	28.77	94	7.5432	72.6281
2025	10	12	14	20	30	28.07	96.3	7.5371	70.544
2025	10	12	14	30	30	28.77	96.2	7.5371	72.3139
2025	10	12	14	40	30	27.89	94.5	7.5371	70.2912
2025	10	12	14	50	30	27.84	95.8	7.5371	70.0383
2025	10	12	15	0	30	28.34	95.7	7.5371	71.3026
2025	10	12	15	10	30	28.21	96.9	7.5371	70.7969
2025	10	12	15	20	30	28.28	98.1	7.531	70.7371
2025	10	12	15	30	30	27.67	96.4	7.531	69.4739
2025	10	12	15	40	30	28.02	95.3	7.531	70.4844
2025	10	12	15	50	30	28.59	96.6	7.531	71.7476

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	12	16	0	30	28.02	95.3	7.531	70.4845
2025	10	12	16	10	30	27.6	95	7.531	69.474
2025	10	12	16	20	30	27.72	97.3	7.5249	69.4152
2025	10	12	16	30	30	27.93	95.5	7.5249	70.1725
2025	10	12	16	40	30	27.18	96.5	7.531	68.2109
2025	10	12	16	50	30	28.36	96.1	7.5188	71.122
2025	10	12	17	0	30	27.81	97	7.5249	69.6677
2025	10	12	17	10	30	28.29	94.5	7.5249	71.1823
2025	10	12	17	20	30	27.92	97.2	7.5249	69.9202
2025	10	12	17	30	30	27.41	95	7.5188	68.8522
2025	10	12	17	40	30	28.79	98.2	7.5249	71.9396
2025	10	12	17	50	30	29.35	95.9	7.5249	73.7065
2025	10	12	18	0	30	28.26	96.1	7.5249	70.9299
2025	10	12	18	10	30	28.75	95.8	7.5249	72.192
2025	10	12	18	20	30	29.03	95.3	7.5249	72.9493
2025	10	12	18	30	30	28.72	95.2	7.5249	72.1921
2025	10	12	18	40	30	28.84	95.6	7.5249	72.4445
2025	10	12	18	50	30	28.92	95.2	7.5249	72.697
2025	10	12	19	0	30	28.37	96.3	7.5249	71.1825
2025	10	12	19	10	30	28.7	96.8	7.5249	71.9398
2025	10	12	19	20	30	27.27	96.3	7.5188	68.348
2025	10	12	19	30	30	27.87	96.4	7.5188	69.8612
2025	10	12	19	40	30	28.46	96.1	7.5188	71.3745
2025	10	12	19	50	30	28.02	97.2	7.5188	70.1135
2025	10	12	20	0	30	29.22	97.1	7.5188	73.14
2025	10	12	20	10	30	29.63	95.4	7.5188	74.4011
2025	10	12	20	20	30	27.19	94.6	7.5188	68.3481
2025	10	12	20	30	30	28.78	96.4	7.5188	72.1313
2025	10	12	20	40	30	27.38	96.5	7.5188	68.6004
2025	10	12	20	50	30	28.12	95.3	7.5188	70.6181
2025	10	12	21	0	30	27.21	91.5	7.5127	68.5423
2025	10	12	21	10	30	28.39	94.4	7.5188	71.3747
2025	10	12	21	20	30	28.98	94.4	7.5188	72.888
2025	10	12	21	30	30	28.7	94.8	7.5127	72.0703
2025	10	12	21	40	30	28.78	96.4	7.5127	72.0703
2025	10	12	21	50	30	28.02	97.2	7.5127	70.0544
2025	10	12	22	0	30	28.58	96.4	7.5127	71.5664
2025	10	12	22	10	30	28.61	97	7.5127	71.5664
2025	10	12	22	20	30	28.7	96.8	7.5127	71.8184
2025	10	12	22	30	30	28.33	95.5	7.5127	71.0624
2025	10	12	22	40	30	28.19	94.5	7.5127	70.8105
2025	10	12	22	50	30	29.22	95.1	7.5127	73.3305
2025	10	12	23	0	30	28.66	96	7.5127	71.8185
2025	10	12	23	10	30	27.85	97.6	7.5127	69.5506
2025	10	12	23	20	30	27.42	95.4	7.5127	68.7946
2025	10	12	23	30	30	28.55	93.4	7.5127	71.8186
2025	10	12	23	40	30	27.42	97.3	7.5127	68.5426
2025	10	12	23	50	30	28.09	94.7	7.5127	70.5586

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	13	0	0	30	28.58	94.2	7.5127	71.8186
2025	10	13	0	10	30	29.21	96.9	7.5127	73.0786
2025	10	13	0	20	30	27.31	95	7.5127	68.5427
2025	10	13	0	30	30	28.79	96.6	7.5127	72.0706
2025	10	13	0	40	30	27.76	96.2	7.5127	69.5507
2025	10	13	0	50	30	28.44	95.7	7.5127	71.3147
2025	10	13	1	0	30	28.26	96.1	7.5066	70.7506
2025	10	13	1	10	30	27.64	95.8	7.5066	69.24
2025	10	13	1	20	30	27.86	93.7	7.5127	70.0547
2025	10	13	1	30	30	28.6	96.8	7.5066	71.506
2025	10	13	1	40	30	28.55	97.6	7.5066	71.2542
2025	10	13	1	50	30	27.36	93.8	7.5066	68.7364
2025	10	13	2	0	30	26.9	97	7.5066	67.2258
2025	10	13	2	10	30	29.24	97.3	7.5066	73.0168
2025	10	13	2	20	30	27.67	96.4	7.5066	69.24
2025	10	13	2	30	30	28.4	96.9	7.5066	71.0025
2025	10	13	2	40	30	28.66	96	7.5066	71.7579
2025	10	13	2	50	30	27.89	94.5	7.5066	69.9954
2025	10	13	3	0	30	27.36	96.3	7.5066	68.4847
2025	10	13	3	10	30	28.49	96.7	7.5066	71.2543
2025	10	13	3	20	30	29.88	96.3	7.5066	74.7793
2025	10	13	3	30	30	27.74	95.8	7.5066	69.4919
2025	10	13	3	40	30	28.33	95.5	7.5066	71.0026
2025	10	13	3	50	30	27.35	93.6	7.5066	68.7365
2025	10	13	4	0	30	29.36	97.6	7.5066	73.2686
2025	10	13	4	10	30	28	94.9	7.5066	70.2472
2025	10	13	4	20	30	28.14	95.7	7.5066	70.499
2025	10	13	4	30	30	28.43	92.8	7.5066	71.5062
2025	10	13	4	40	30	27.99	94.5	7.5066	70.2473
2025	10	13	4	50	30	28.29	94.5	7.5066	71.0026
2025	10	13	5	0	30	28.09	94.5	7.5066	70.4991
2025	10	13	5	10	30	27.67	96.4	7.5066	69.2402
2025	10	13	5	20	30	29.06	95.9	7.5066	72.7651
2025	10	13	5	30	30	27.8	95	7.5066	69.7438
2025	10	13	5	40	30	28.97	94	7.5066	72.7652
2025	10	13	5	50	30	28.39	94.6	7.5066	71.2545
2025	10	13	6	0	30	28.47	94	7.5066	71.5063
2025	10	13	6	10	30	28.12	95.3	7.5066	70.4992
2025	10	13	6	20	30	28.82	95.2	7.5066	72.2616
2025	10	13	6	30	30	28.72	95.2	7.5066	72.0099
2025	10	13	6	40	30	27.29	94.6	7.5066	68.4849
2025	10	13	6	50	30	28.95	93.4	7.5066	72.7652
2025	10	13	7	0	30	26.29	94.8	7.5066	65.9671
2025	10	13	7	10	30	28.24	95.7	7.5066	70.751
2025	10	13	7	20	30	28.12	97.2	7.5066	70.2475
2025	10	13	7	30	30	29.42	97	7.5066	73.5207
2025	10	13	7	40	30	28.12	95.3	7.5066	70.4993
2025	10	13	7	50	30	28.3	94.9	7.5066	71.0029

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	13	8	0	30	29.15	95.9	7.5066	73.0171
2025	10	13	8	10	30	28.44	95.7	7.5066	71.2547
2025	10	13	8	20	30	27.48	94.4	7.5066	68.9886
2025	10	13	8	30	30	28.11	96.9	7.5066	70.2476
2025	10	13	8	40	30	28.45	95.9	7.5066	71.2547
2025	10	13	8	50	30	26.48	94.5	7.5066	66.4708
2025	10	13	9	0	30	27.86	96.2	7.5127	69.8031
2025	10	13	9	10	30	27.19	94.6	7.5127	68.2911
2025	10	13	9	20	30	28.42	97.1	7.5127	71.0631
2025	10	13	9	30	30	27.22	95.5	7.5127	68.2911
2025	10	13	9	40	30	27.77	96.4	7.5127	69.5511
2025	10	13	9	50	30	28.82	95.2	7.5127	72.323
2025	10	13	10	0	30	28.01	97	7.5127	70.055
2025	10	13	10	10	30	28.96	95.9	7.5127	72.575
2025	10	13	10	20	30	28.42	95.2	7.5127	71.315
2025	10	13	10	30	30	28.19	94.5	7.5127	70.811
2025	10	13	10	40	30	28.94	95.6	7.5127	72.5749
2025	10	13	10	50	30	28.93	95.4	7.5127	72.5749
2025	10	13	11	0	30	27.7	96.8	7.5127	69.299
2025	10	13	11	10	30	27.97	96.4	7.5127	70.055
2025	10	13	11	20	30	27.94	95.8	7.5127	70.055
2025	10	13	11	30	30	27.97	96.4	7.5127	70.055
2025	10	13	11	40	30	28.02	92.2	7.5127	70.5591
2025	10	13	11	50	30	28.45	97.7	7.5127	71.063
2025	10	13	12	0	30	28.4	96.9	7.5127	71.063
2025	10	13	12	10	30	27.38	98.2	7.5127	68.2911
2025	10	13	12	20	30	29.09	96.5	7.5127	72.827
2025	10	13	12	30	30	29.2	96.7	7.5127	73.0789
2025	10	13	12	40	30	28.11	96.9	7.5066	70.2474
2025	10	13	12	50	30	27.62	95.4	7.5066	69.2403
2025	10	13	13	0	30	28.56	96	7.5005	71.4456
2025	10	13	13	10	30	26.75	93.6	7.5066	67.226
2025	10	13	13	20	30	27.52	95.4	7.5005	68.93
2025	10	13	13	30	30	27.18	94.4	7.5005	68.1753
2025	10	13	13	40	30	27.08	94.4	7.5127	68.0391
2025	10	13	13	50	30	28.06	96.1	7.5066	70.2475
2025	10	13	14	0	30	27.05	93.4	7.5066	67.9815
2025	10	13	14	10	30	27.56	93.7	7.5066	69.2404
2025	10	13	14	20	30	28.47	96.3	7.5066	71.2547
2025	10	13	14	30	30	28.13	97.4	7.5066	70.2475
2025	10	13	14	40	30	28.16	96.1	7.5066	70.4993
2025	10	13	14	50	30	27.94	95.8	7.5005	69.9364
2025	10	13	15	0	30	28.54	95.6	7.5005	71.4458
2025	10	13	15	10	30	27.96	96.2	7.4944	69.877
2025	10	13	15	20	30	28.76	96	7.5005	71.949
2025	10	13	15	30	30	27.65	96	7.5066	69.2405
2025	10	13	15	40	30	27.53	95.6	7.5066	68.9887
2025	10	13	15	50	30	28.17	98	7.5066	70.2476

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	13	16	0	30	28.13	95.5	7.5066	70.4994
2025	10	13	16	10	30	27.54	97.5	7.5066	68.7369
2025	10	13	16	20	30	27.46	96.3	7.5005	68.6786
2025	10	13	16	30	30	28.21	96.9	7.4944	70.3798
2025	10	13	16	40	30	28	96.8	7.5005	69.9365
2025	10	13	16	50	30	27.17	96.3	7.5066	67.9816
2025	10	13	17	0	30	27.11	95.1	7.5005	67.924
2025	10	13	17	10	30	28.01	95.1	7.5005	70.1881
2025	10	13	17	20	30	27.34	93.1	7.4944	68.6204
2025	10	13	17	30	30	27.94	95.8	7.5066	69.996
2025	10	13	17	40	30	26.78	94.5	7.5005	67.1694
2025	10	13	17	50	30	27.58	94.4	7.5005	69.1819
2025	10	13	18	0	30	27.83	95.6	7.5066	69.7443
2025	10	13	18	10	30	27.79	94.5	7.5066	69.7443
2025	10	13	18	20	30	28.25	95.9	7.5005	70.6915
2025	10	13	18	30	30	28.63	92.4	7.5005	71.9493
2025	10	13	18	40	30	28.01	97	7.5005	69.9368
2025	10	13	18	50	30	28.6	96.8	7.5066	71.507
2025	10	13	19	0	30	26.97	96.4	7.5066	67.4784
2025	10	13	19	10	30	27.42	95.4	7.5005	68.6791
2025	10	13	19	20	30	28.56	93.8	7.5005	71.6979
2025	10	13	19	30	30	28.21	96.9	7.5005	70.4401
2025	10	13	19	40	30	28.52	97.1	7.5066	71.2553
2025	10	13	19	50	30	26.91	95.1	7.4944	67.364
2025	10	13	20	0	30	27.71	95.2	7.5066	69.4929
2025	10	13	20	10	30	27.31	95	7.5005	68.4277
2025	10	13	20	20	30	28.43	97.3	7.5066	71.0037
2025	10	13	20	30	30	28.7	94.8	7.5005	71.9497
2025	10	13	20	40	30	27.52	95.4	7.5066	68.9894
2025	10	13	20	50	30	28.84	97.4	7.5066	72.0109
2025	10	13	21	0	30	27.75	93.5	7.5005	69.6856
2025	10	13	21	10	30	26.53	95.6	7.5127	66.528
2025	10	13	21	20	30	27.45	96.1	7.5066	68.7377
2025	10	13	21	30	30	27.12	95.3	7.5066	67.9824
2025	10	13	21	40	30	27.82	95.4	7.5066	69.7449
2025	10	13	21	50	30	27.59	94.6	7.5066	69.2413
2025	10	13	22	0	30	27.36	96.3	7.5005	68.4279
2025	10	13	22	10	30	28.63	97.2	7.5005	71.4467
2025	10	13	22	20	30	27.76	93.7	7.5066	69.745
2025	10	13	22	30	30	28.45	93.4	7.5066	71.5075
2025	10	13	22	40	30	28.49	94.4	7.5066	71.5075
2025	10	13	22	50	30	29.11	94.9	7.5005	72.9562
2025	10	13	23	0	30	27.98	96.6	7.5005	69.9374
2025	10	13	23	10	30	27.76	96.2	7.5005	69.4342
2025	10	13	23	20	30	27.98	96.6	7.5066	69.9968
2025	10	13	23	30	30	27.76	96.2	7.4944	69.3753
2025	10	13	23	40	30	27.39	94.6	7.5066	68.7379
2025	10	13	23	50	30	28.25	95.9	7.5005	70.6921

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	14	0	0	30	27.8	94.7	7.5066	69.745
2025	10	14	0	10	30	27.65	96	7.5066	69.2414
2025	10	14	0	20	30	26.82	95.3	7.5005	67.1701
2025	10	14	0	30	30	28.41	95	7.5127	71.3162
2025	10	14	0	40	30	27.56	97.9	7.5066	68.7379
2025	10	14	0	50	30	27.58	94.4	7.5127	69.3002
2025	10	14	1	0	30	27.36	96.3	7.5066	68.4861
2025	10	14	1	10	30	27.24	95.9	7.5066	68.2343
2025	10	14	1	20	30	28.64	95.6	7.5127	71.8202
2025	10	14	1	30	30	27.4	96.9	7.5005	68.428
2025	10	14	1	40	30	28.2	98.4	7.5127	70.3082
2025	10	14	1	50	30	28.64	95.6	7.5066	71.7593
2025	10	14	2	0	30	27.67	96.4	7.5066	69.2415
2025	10	14	2	10	30	27.4	96.9	7.5127	68.5442
2025	10	14	2	20	30	28.81	97	7.5127	72.0722
2025	10	14	2	30	30	28.88	94.2	7.5066	72.5147
2025	10	14	2	40	30	28.12	95.3	7.5066	70.5004
2025	10	14	2	50	30	27.3	94.8	7.5005	68.428
2025	10	14	3	0	30	28.28	96.5	7.5066	70.7522
2025	10	14	3	10	30	27.48	94.4	7.5066	68.9896
2025	10	14	3	20	30	28.98	94.4	7.5127	72.8282
2025	10	14	3	30	30	28.5	96.9	7.5127	71.3162
2025	10	14	3	40	30	27.51	97.1	7.5066	68.7378
2025	10	14	3	50	30	27.17	96.3	7.5127	68.0402
2025	10	14	4	0	30	27.76	97.9	7.5066	69.2414
2025	10	14	4	10	30	28.5	94.8	7.5066	71.5075
2025	10	14	4	20	30	28.21	96.9	7.5066	70.5003
2025	10	14	4	30	30	27.85	93.5	7.5005	69.9373
2025	10	14	4	40	30	27.87	96.4	7.5066	69.745
2025	10	14	4	50	30	27.22	95.5	7.5066	68.2342
2025	10	14	5	0	30	27.75	96	7.5127	69.5521
2025	10	14	5	10	30	27.98	94.3	7.5127	70.3081
2025	10	14	5	20	30	27.58	94.4	7.5127	69.3001
2025	10	14	5	30	30	28.09	94.7	7.5127	70.5601
2025	10	14	5	40	30	27.51	95.2	7.5066	68.9896
2025	10	14	5	50	30	28.11	96.9	7.5066	70.2485
2025	10	14	6	0	30	28.11	95.1	7.5127	70.5601
2025	10	14	6	10	30	27.58	94.4	7.5127	69.3001
2025	10	14	6	20	30	28.09	98.2	7.5188	70.1155
2025	10	14	6	30	30	28.1	94.9	7.5127	70.5601
2025	10	14	6	40	30	27.89	98.2	7.5127	69.5522
2025	10	14	6	50	30	27.99	94.7	7.5249	70.4274
2025	10	14	7	0	30	27.91	97	7.5188	69.8634
2025	10	14	7	10	30	28.21	96.9	7.5188	70.62
2025	10	14	7	20	30	27.05	97.9	7.5127	67.5362
2025	10	14	7	30	30	27.23	95.7	7.5127	68.2922
2025	10	14	7	40	30	26.68	94.5	7.5127	67.0322
2025	10	14	7	50	30	26.91	95.1	7.5188	67.5935

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	14	8	0	30	27.69	94.6	7.5249	69.6702
2025	10	14	8	10	30	28.2	94.9	7.5249	70.9323
2025	10	14	8	20	30	28.23	95.5	7.5127	70.8122
2025	10	14	8	30	30	27.27	94.2	7.5188	68.6024
2025	10	14	8	40	30	28.16	96.1	7.5188	70.6201
2025	10	14	8	50	30	28.32	95.3	7.531	71.245
2025	10	14	9	0	30	28.11	96.9	7.531	70.4871
2025	10	14	9	10	30	28.07	94.1	7.5371	70.7996
2025	10	14	9	20	30	27.82	95.4	7.5371	70.041
2025	10	14	9	30	30	27.69	94.6	7.5432	69.8472
2025	10	14	9	40	30	27.56	93.7	7.5493	69.6529
2025	10	14	9	50	30	28.01	95.1	7.5493	70.666
2025	10	14	10	0	30	27.47	94.2	7.5493	69.3996
2025	10	14	10	10	30	26.88	94.5	7.5554	67.9372
2025	10	14	10	20	30	27.15	93.6	7.5554	68.6977
2025	10	14	10	30	30	28.48	94.2	7.5615	72.0538
2025	10	14	10	40	30	28.02	95.3	7.5615	70.7853
2025	10	14	10	50	30	28.07	96.3	7.5676	70.8449
2025	10	14	11	0	30	28.48	94.2	7.5676	72.1146
2025	10	14	11	10	30	28.21	95.1	7.5737	71.4128
2025	10	14	11	20	30	27.96	97.8	7.5737	70.3963
2025	10	14	11	30	30	28.62	95.2	7.5737	72.4294
2025	10	14	11	40	30	28.17	96.3	7.5798	71.2186
2025	10	14	11	50	30	28.76	96	7.5859	72.8058
2025	10	14	12	0	30	27.71	95.2	7.5798	70.2012
2025	10	14	12	10	30	28.57	94	7.5859	72.5513
2025	10	14	12	20	30	27.87	96.4	7.592	70.574
2025	10	14	12	30	30	27.78	94.3	7.6041	70.6924
2025	10	14	12	40	30	28.14	95.7	7.6163	71.5778
2025	10	14	12	50	30	28.25	95.9	7.6224	71.8935
2025	10	14	13	0	30	27.77	94.1	7.6285	70.9293
2025	10	14	13	10	30	28.26	93.7	7.6346	72.2699
2025	10	14	13	20	30	28.78	94.2	7.6346	73.5513
2025	10	14	13	30	30	27.88	94.3	7.6407	71.3043
2025	10	14	13	40	30	27.86	93.9	7.6346	71.2449
2025	10	14	13	50	30	28.5	94.8	7.6407	72.8433
2025	10	14	14	0	30	28.36	93.6	7.6407	72.5868
2025	10	14	14	10	30	27.34	92.9	7.6468	70.0803
2025	10	14	14	20	30	28.76	93.6	7.6529	73.7355
2025	10	14	14	30	30	28.07	94.1	7.6468	71.8772
2025	10	14	14	40	30	27.77	94.1	7.6468	71.1069
2025	10	14	14	50	30	27.03	92.8	7.659	69.4254
2025	10	14	15	0	30	27.15	93.6	7.6651	69.7405
2025	10	14	15	10	30	27.54	93.1	7.659	70.7111
2025	10	14	15	20	30	27.97	96.4	7.6529	71.4231
2025	10	14	15	30	30	28.38	94.2	7.6651	72.8287
2025	10	14	15	40	30	28.29	94.5	7.659	72.5111
2025	10	14	15	50	30	28.26	93.9	7.6651	72.5714

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	14	16	0	30	28.26	96.1	7.6712	72.3742
2025	10	14	16	10	30	27.24	93.2	7.6773	70.1143
2025	10	14	16	20	30	28.38	94.2	7.6712	72.8893
2025	10	14	16	30	30	27.53	92.5	7.6773	70.8877
2025	10	14	16	40	30	28.21	95.1	7.6773	72.4343
2025	10	14	16	50	30	28.86	96	7.6712	73.9197
2025	10	14	17	0	30	29.11	94.9	7.6712	74.6924
2025	10	14	17	10	30	28.22	95.3	7.6773	72.4344
2025	10	14	17	20	30	28.97	96.1	7.6712	74.1773
2025	10	14	17	30	30	28.01	97	7.6712	71.6017
2025	10	14	17	40	30	28.12	95.3	7.6834	72.2365
2025	10	14	17	50	30	28.34	93	7.6773	72.95
2025	10	14	18	0	30	28.57	94	7.6834	73.5265
2025	10	14	18	10	30	27.73	95.6	7.6773	71.1457
2025	10	14	18	20	30	29.1	96.7	7.6773	74.4967
2025	10	14	18	30	30	28.35	95.9	7.6834	72.7526
2025	10	14	18	40	30	27.62	95.4	7.6712	70.8291
2025	10	14	18	50	30	28.33	92.6	7.6773	72.9502
2025	10	14	19	0	30	28.08	96.5	7.6773	71.9191
2025	10	14	19	10	30	27.68	94.4	7.6773	71.1458
2025	10	14	19	20	30	28.65	95.8	7.6834	73.5267
2025	10	14	19	30	30	28.55	95.8	7.6712	73.1473
2025	10	14	19	40	30	28.63	92.4	7.6773	73.7236
2025	10	14	19	50	30	28.55	95.8	7.6773	73.2081
2025	10	14	20	0	30	28.77	94	7.6773	73.9814
2025	10	14	20	10	30	28.52	95.2	7.6773	73.2081
2025	10	14	20	20	30	28.05	93.5	7.6773	72.177
2025	10	14	20	30	30	28.22	95.3	7.6773	72.4348
2025	10	14	20	40	30	29.32	95.1	7.6834	75.3328
2025	10	14	20	50	30	29.39	94.5	7.6834	75.5908
2025	10	14	21	0	30	29.03	95.3	7.6834	74.5588
2025	10	14	21	10	30	28.58	96.4	7.6834	73.2689
2025	10	14	21	20	30	28.18	96.5	7.6834	72.237
2025	10	14	21	30	30	28.11	95.1	7.6773	72.1771
2025	10	14	21	40	30	28.51	95	7.6834	73.2689
2025	10	14	21	50	30	28.63	95.4	7.6773	73.466
2025	10	14	22	0	30	29.49	94.5	7.6773	75.786
2025	10	14	22	10	30	29.39	96.4	7.6773	75.2705
2025	10	14	22	20	30	29.78	97.9	7.6773	76.0438
2025	10	14	22	30	30	28.58	94.4	7.6834	73.527
2025	10	14	22	40	30	28.39	96.7	7.6773	72.6927
2025	10	14	22	50	30	27.98	94.3	7.6773	71.9194
2025	10	14	23	0	30	27.99	94.5	7.6773	71.9194
2025	10	14	23	10	30	28.29	94.5	7.6773	72.6928
2025	10	14	23	20	30	29.14	95.7	7.6773	74.755
2025	10	14	23	30	30	29.69	94.4	7.6773	76.3017
2025	10	14	23	40	30	28.25	93.4	7.6773	72.6928
2025	10	14	23	50	30	28.85	95.8	7.6773	73.9817

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	15	0	0	30	28.14	95.7	7.6834	72.2372
2025	10	15	0	10	30	28.75	95.8	7.6834	73.7851
2025	10	15	0	20	30	29.33	95.5	7.6773	75.2706
2025	10	15	0	30	30	28.95	95.7	7.6773	74.2396
2025	10	15	0	40	30	29.84	97.3	7.6773	76.3018
2025	10	15	0	50	30	28.25	95.9	7.6773	72.4351
2025	10	15	1	0	30	28.22	97.1	7.6773	72.1774
2025	10	15	1	10	30	28.92	95.2	7.6773	74.2396
2025	10	15	1	20	30	29.66	97.6	7.6773	75.7862
2025	10	15	1	30	30	29.07	96.1	7.6773	74.4974
2025	10	15	1	40	30	30.62	98.3	7.6773	78.1062
2025	10	15	1	50	30	30.22	95.1	7.6773	77.5907
2025	10	15	2	0	30	28.85	95.8	7.6773	73.9818
2025	10	15	2	10	30	28.18	96.5	7.6773	72.1774
2025	10	15	2	20	30	28.06	93.9	7.6773	72.1774
2025	10	15	2	30	30	29.21	94.9	7.6773	75.013
2025	10	15	2	40	30	29.33	97.2	7.6773	75.013
2025	10	15	2	50	30	29.84	97.3	7.6773	76.3019
2025	10	15	3	0	30	29.31	96.9	7.6773	75.013
2025	10	15	3	10	30	28.89	96.6	7.6773	73.9819
2025	10	15	3	20	30	29.04	95.5	7.6773	74.4975
2025	10	15	3	30	30	28.63	97.2	7.6773	73.2086
2025	10	15	3	40	30	29.23	95.5	7.6773	75.0131
2025	10	15	3	50	30	28.66	96	7.6773	73.4664
2025	10	15	4	0	30	27.16	96.1	7.6773	69.5998
2025	10	15	4	10	30	28.41	95	7.6773	72.9509
2025	10	15	4	20	30	27.74	95.8	7.6773	71.1465
2025	10	15	4	30	30	29.21	96.9	7.6773	74.7553
2025	10	15	4	40	30	28.83	97.2	7.6773	73.7243
2025	10	15	4	50	30	28.9	94.8	7.6773	74.2399
2025	10	15	5	0	30	29.39	96.4	7.6773	75.271
2025	10	15	5	10	30	27.42	97.3	7.6773	70.1154
2025	10	15	5	20	30	28.49	96.7	7.6773	72.951
2025	10	15	5	30	30	29.18	96.3	7.6773	74.7555
2025	10	15	5	40	30	29.42	95.3	7.6773	75.5288
2025	10	15	5	50	30	28.58	94.4	7.6712	73.4057
2025	10	15	6	0	30	28.68	94.4	7.6712	73.6633
2025	10	15	6	10	30	27.85	93.3	7.6712	71.6028
2025	10	15	6	20	30	29.34	95.7	7.6712	75.2087
2025	10	15	6	30	30	29.53	95.4	7.6712	75.7239
2025	10	15	6	40	30	29.04	95.5	7.6712	74.4361
2025	10	15	6	50	30	29.26	97.7	7.6712	74.6937
2025	10	15	7	0	30	29.54	95.6	7.6712	75.724
2025	10	15	7	10	30	28.25	95.9	7.6712	72.3756
2025	10	15	7	20	30	30.47	96	7.6712	78.0421
2025	10	15	7	30	30	28.34	95.7	7.6712	72.6332
2025	10	15	7	40	30	29.11	94.9	7.6712	74.6938
2025	10	15	7	50	30	28.54	97.4	7.6712	72.8908

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	15	8	0	30	30.03	97.1	7.6712	76.7543
2025	10	15	8	10	30	28.49	96.7	7.6712	72.8909
2025	10	15	8	20	30	28.55	95.8	7.6712	73.1484
2025	10	15	8	30	30	29.36	96.1	7.6712	75.209
2025	10	15	8	40	30	27.56	97.9	7.6712	70.3152
2025	10	15	8	50	30	29.71	94.8	7.6712	76.2392
2025	10	15	9	0	30	28.31	95.1	7.6712	72.6332
2025	10	15	9	10	30	27.98	96.6	7.6712	71.603
2025	10	15	9	20	30	28.05	95.9	7.6712	71.8605
2025	10	15	9	30	30	29.21	94.9	7.6712	74.9513
2025	10	15	9	40	30	28.37	96.3	7.6712	72.6332
2025	10	15	9	50	30	27.9	96.8	7.6712	71.3453
2025	10	15	10	2	15	28.38	96.5	7.6712	72.6331
2025	10	15	10	12	15	27.94	95.8	7.6712	71.6028
2025	10	15	10	22	15	28	96.8	7.6712	71.6028
2025	10	15	10	32	15	30.23	95.3	7.6712	77.5267
2025	10	15	10	42	15	28.54	95.6	7.6712	73.1481
2025	10	15	10	52	15	29.22	95.3	7.6712	74.951
2025	10	15	11	2	15	27.78	94.3	7.6773	71.4043
2025	10	15	11	12	15	27.55	96	7.6773	70.631
2025	10	15	11	22	15	28.07	96.3	7.6712	71.8602
2025	10	15	11	32	15	27.2	97	7.6712	69.5421
2025	10	15	11	42	15	27.97	94.1	7.6712	71.8601
2025	10	15	11	52	15	28.35	95.9	7.6773	72.6931
2025	10	15	12	2	15	28.38	96.5	7.6712	72.6328
2025	10	15	12	12	15	28.04	95.7	7.6712	71.86
2025	10	15	12	22	15	28.59	96.6	7.6712	73.1478
2025	10	15	12	32	15	28.89	96.6	7.6712	73.9205
2025	10	15	12	42	15	28.65	95.8	7.6712	73.4054
2025	10	15	12	52	15	28.47	96.3	7.6712	72.8902
2025	10	15	13	2	15	30.22	98.4	7.6712	77.0112
2025	10	15	13	12	15	28.87	96.2	7.6712	73.9204
2025	10	15	13	22	15	29.36	93.7	7.6712	75.4658
2025	10	15	13	32	15	27.77	96.4	7.6712	71.0872
2025	10	15	13	42	15	28.54	95.6	7.6712	73.1477
2025	10	15	13	52	15	28.45	95.9	7.6712	72.8901
2025	10	15	14	2	15	28.18	94.3	7.6712	72.375
2025	10	15	14	12	15	28.63	95.4	7.6712	73.4052
2025	10	15	14	22	15	28.86	96	7.6712	73.9203
2025	10	15	14	32	15	28.38	94.2	7.6712	72.8901
2025	10	15	14	42	15	28.47	96.3	7.6712	72.8901
2025	10	15	14	52	15	27.88	96.6	7.6651	71.2855
2025	10	15	15	2	15	28.15	95.9	7.6651	72.0575
2025	10	15	15	12	15	27.88	94.3	7.6651	71.5428
2025	10	15	15	22	15	28.45	95.9	7.6651	72.8296
2025	10	15	15	32	15	28.6	94.8	7.6651	73.3442
2025	10	15	15	42	15	28.54	93.2	7.6651	73.3442
2025	10	15	15	52	15	29.34	95.7	7.6651	75.1457

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	15	16	2	15	28.05	93.5	7.6651	72.0576
2025	10	15	16	12	15	29.12	97.1	7.6651	74.3737
2025	10	15	16	22	15	28.5	96.9	7.6651	72.8296
2025	10	15	16	32	15	29.26	96.1	7.6651	74.8884
2025	10	15	16	42	15	29.81	96.7	7.6651	76.1751
2025	10	15	16	52	15	28.14	95.7	7.659	71.9977
2025	10	15	17	2	15	28.52	95.2	7.659	73.0263
2025	10	15	17	12	15	28.89	94.6	7.6651	74.1164
2025	10	15	17	22	15	27.51	95.2	7.659	70.4549
2025	10	15	17	32	15	28.24	97.5	7.659	71.9977
2025	10	15	17	42	15	28.12	97.2	7.6651	71.8002
2025	10	15	17	52	15	28.72	95.2	7.659	73.5405
2025	10	15	18	2	15	29.49	96.4	7.659	75.3405
2025	10	15	18	12	15	28.33	97.3	7.659	72.2549
2025	10	15	18	22	15	28.63	97.2	7.659	73.0263
2025	10	15	18	32	15	29.15	95.9	7.659	74.5691
2025	10	15	18	42	15	28.86	96	7.659	73.7977
2025	10	15	18	52	15	28.48	94.2	7.659	73.0263
2025	10	15	19	2	15	29.21	94.9	7.659	74.8263
2025	10	15	19	12	15	28.3	96.9	7.659	72.2549
2025	10	15	19	22	15	27.83	95.6	7.659	71.2264
2025	10	15	19	32	15	29.75	95.8	7.659	76.112
2025	10	15	19	42	15	28.6	98.2	7.659	72.7692
2025	10	15	19	52	15	29.18	94.1	7.659	74.8264
2025	10	15	20	2	15	28.49	96.7	7.659	72.7693
2025	10	15	20	12	15	30.36	97.6	7.659	77.3977
2025	10	15	20	22	15	28.89	96.6	7.659	73.7979
2025	10	15	20	32	15	29.34	95.7	7.659	75.0835
2025	10	15	20	42	15	28.99	94.6	7.659	74.3121
2025	10	15	20	52	15	29.53	95.4	7.659	75.5978
2025	10	15	21	2	15	29.93	95.4	7.659	76.6264
2025	10	15	21	12	15	29.12	98.5	7.659	74.0551
2025	10	15	21	22	15	30.47	96	7.659	77.9121
2025	10	15	21	32	15	28.31	95.1	7.659	72.5123
2025	10	15	21	42	15	29.64	95.6	7.659	75.855
2025	10	15	21	52	15	28.31	95.1	7.659	72.5123
2025	10	15	22	2	15	29.56	93.7	7.659	75.8551
2025	10	15	22	12	15	28.71	95	7.659	73.5408
2025	10	15	22	22	15	29.01	94.9	7.659	74.3123
2025	10	15	22	32	15	29.53	95.4	7.659	75.598
2025	10	15	22	42	15	28.69	94.6	7.659	73.5409
2025	10	15	22	52	15	28.61	95	7.659	73.2838
2025	10	15	23	2	15	29.14	95.7	7.659	74.5694
2025	10	15	23	12	15	27.56	96.2	7.659	70.4553
2025	10	15	23	22	15	28.75	95.8	7.659	73.5409
2025	10	15	23	32	15	29.15	95.9	7.659	74.5695
2025	10	15	23	42	15	30.1	96.7	7.6529	76.8198
2025	10	15	23	52	15	28.19	94.7	7.659	72.2553

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	16	0	2	15	27.94	95.8	7.659	71.4839
2025	10	16	0	12	15	28.28	94.3	7.659	72.5124
2025	10	16	0	22	15	29.7	96.6	7.659	75.8552
2025	10	16	0	32	15	28.31	95.1	7.659	72.5124
2025	10	16	0	42	15	29.39	96.4	7.659	75.0838
2025	10	16	0	52	15	28.82	95.2	7.659	73.7981
2025	10	16	1	2	15	27.97	94.1	7.659	71.741
2025	10	16	1	12	15	28.43	95.4	7.659	72.7696
2025	10	16	1	22	15	28.08	94.3	7.659	71.9982
2025	10	16	1	32	15	27.22	95.3	7.659	69.6839
2025	10	16	1	42	15	28.85	93.4	7.659	74.0552
2025	10	16	1	52	15	28.43	95.4	7.659	72.7696
2025	10	16	2	2	15	28.05	95.9	7.659	71.741
2025	10	16	2	12	15	30.02	96.9	7.659	76.6266
2025	10	16	2	22	15	29.92	95.2	7.659	76.6266
2025	10	16	2	32	15	28.37	96.3	7.659	72.5124
2025	10	16	2	42	15	29.17	96.1	7.659	74.5695
2025	10	16	2	52	15	29.29	96.5	7.659	74.8266
2025	10	16	3	2	15	29.21	94.9	7.659	74.8266
2025	10	16	3	12	15	29.29	94.5	7.659	75.0837
2025	10	16	3	22	15	27.37	94.2	7.659	70.1982
2025	10	16	3	32	15	28	96.8	7.659	71.4838
2025	10	16	3	42	15	29.04	98.7	7.659	73.7981
2025	10	16	3	52	15	28.39	96.7	7.659	72.5124
2025	10	16	4	2	15	27.52	95.4	7.659	70.4553
2025	10	16	4	12	15	28.26	93.9	7.659	72.5124
2025	10	16	4	22	15	27.96	93.7	7.659	71.741
2025	10	16	4	32	15	28.97	94	7.659	74.3123
2025	10	16	4	42	15	27.95	96	7.659	71.4838
2025	10	16	4	52	15	28.35	93.4	7.659	72.7695
2025	10	16	5	2	15	29.43	95.5	7.659	75.3409
2025	10	16	5	12	15	29.17	96.1	7.659	74.5695
2025	10	16	5	22	15	28.92	97.1	7.659	73.798
2025	10	16	5	32	15	27.99	94.7	7.659	71.741
2025	10	16	5	42	15	28.61	95	7.659	73.2838
2025	10	16	5	52	15	28.84	93.2	7.659	74.0552
2025	10	16	6	2	15	29.96	95.9	7.659	76.6265
2025	10	16	6	12	15	28.6	96.8	7.659	73.0266
2025	10	16	6	22	15	28.74	95.6	7.659	73.5409
2025	10	16	6	32	15	29.33	92.7	7.659	75.3409
2025	10	16	6	42	15	29.71	94.8	7.659	76.1123
2025	10	16	6	52	15	28.45	95.9	7.659	72.7695
2025	10	16	7	2	15	28.02	95.3	7.659	71.741
2025	10	16	7	12	15	27.53	95.6	7.659	70.4553
2025	10	16	7	22	15	29.17	96.1	7.659	74.5695
2025	10	16	7	32	15	27.88	94.3	7.659	71.4838
2025	10	16	7	42	15	28.55	93.4	7.659	73.2838
2025	10	16	7	52	15	28.83	95.4	7.659	73.7981

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	16	8	2	15	29.36	96.1	7.659	75.0838
2025	10	16	8	12	15	28.31	95.1	7.659	72.5124
2025	10	16	8	22	15	27.88	94.3	7.659	71.4839
2025	10	16	8	32	15	29.1	94.7	7.659	74.5695
2025	10	16	8	42	15	27.5	94.8	7.659	70.4553
2025	10	16	8	52	15	28.55	95.8	7.659	73.0266
2025	10	16	9	2	15	27.45	93.6	7.659	70.4552
2025	10	16	9	12	15	28.83	92.8	7.6651	74.1167
2025	10	16	9	22	15	28.11	95.1	7.659	71.998
2025	10	16	9	32	15	28.59	96.6	7.6651	73.0872
2025	10	16	9	42	15	28.74	95.6	7.6651	73.6019
2025	10	16	9	52	15	28.39	94.6	7.6651	72.8298
2025	10	16	10	2	15	28.25	93.4	7.6651	72.5724
2025	10	16	10	12	15	28.43	92.6	7.6651	73.0871
2025	10	16	10	22	15	28.43	95.4	7.6651	72.8297
2025	10	16	10	32	15	29.19	94.5	7.6651	74.8885
2025	10	16	10	42	15	29.22	95.1	7.6651	74.8884
2025	10	16	10	52	15	28.74	97.4	7.6651	73.3443
2025	10	16	11	2	15	28.8	94.8	7.6651	73.859
2025	10	16	11	12	15	28.52	95.2	7.6651	73.0869
2025	10	16	11	22	15	27.85	96	7.6651	71.2855
2025	10	16	11	32	15	27.48	94.4	7.6651	70.5134
2025	10	16	11	42	15	28.39	94.6	7.659	72.769
2025	10	16	11	52	15	28.49	96.7	7.6651	72.8295
2025	10	16	12	2	15	28.09	94.5	7.659	71.9975
2025	10	16	12	12	15	28.28	94.3	7.659	72.5118
2025	10	16	12	22	15	27.48	96.5	7.6651	70.2559
2025	10	16	12	32	15	27.69	94.6	7.6651	71.028
2025	10	16	12	42	15	28.24	95.7	7.6651	72.3147
2025	10	16	12	52	15	27.72	95.4	7.6651	71.0279
2025	10	16	13	2	15	27.51	95.2	7.659	70.4547
2025	10	16	13	12	15	27.35	96.1	7.6651	69.9985
2025	10	16	13	22	15	27.65	93.5	7.6651	71.0279
2025	10	16	13	32	15	27.81	95.2	7.659	71.226
2025	10	16	13	42	15	28.91	97	7.6651	73.8587
2025	10	16	13	52	15	28.51	95	7.6651	73.0867
2025	10	16	14	2	15	28.24	95.7	7.659	72.2545
2025	10	16	14	12	15	28.31	95.1	7.6651	72.572
2025	10	16	14	22	15	28.66	93.6	7.6651	73.6013
2025	10	16	14	32	15	29.34	95.7	7.6651	75.1455
2025	10	16	14	42	15	28.17	94.1	7.6651	72.3146
2025	10	16	14	52	15	28.21	95.1	7.6651	72.3146
2025	10	16	15	2	15	28.73	92.4	7.6651	73.8587
2025	10	16	15	12	15	29.29	96.5	7.6651	74.8881
2025	10	16	15	22	15	29.07	93.9	7.659	74.5688
2025	10	16	15	32	15	28.48	94.2	7.6651	73.0867
2025	10	16	15	42	15	28.01	95.1	7.659	71.7404
2025	10	16	15	52	15	26.71	95.2	7.6651	68.4545

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	16	16	2	15	28.48	94.2	7.6651	73.0868
2025	10	16	16	12	15	28.21	95.1	7.6651	72.3148
2025	10	16	16	22	15	27.3	94.8	7.6651	69.9987
2025	10	16	16	32	15	28.38	96.5	7.6651	72.5722
2025	10	16	16	42	15	27.89	94.7	7.6651	71.5428
2025	10	16	16	52	15	28.13	95.5	7.6651	72.0575
2025	10	16	17	2	15	29.32	95.1	7.6651	75.1457
2025	10	16	17	12	15	28.57	96.2	7.6651	73.0869
2025	10	16	17	22	15	28.93	92.6	7.6651	74.3737
2025	10	16	17	32	15	28.66	93.6	7.6651	73.6017
2025	10	16	17	42	15	28.61	95	7.6651	73.3443
2025	10	16	17	52	15	28.95	95.7	7.6651	74.1164
2025	10	16	18	2	15	29.24	95.7	7.6651	74.8885
2025	10	16	18	12	15	28.14	97.6	7.6651	71.8003
2025	10	16	18	22	15	28.88	94.4	7.6651	74.1165
2025	10	16	18	32	15	27.74	95.8	7.6651	71.0283
2025	10	16	18	42	15	29.31	96.9	7.6651	74.8885
2025	10	16	18	52	15	29.33	95.5	7.6651	75.1459
2025	10	16	19	2	15	28.89	96.6	7.6651	73.8592
2025	10	16	19	12	15	28.99	96.5	7.6651	74.1166
2025	10	16	19	22	15	29.79	99.3	7.6651	75.6607
2025	10	16	19	32	15	29.66	96	7.6651	75.9181
2025	10	16	19	42	15	28.16	93.7	7.6651	72.3152
2025	10	16	19	52	15	28.94	97.3	7.6651	73.8593
2025	10	16	20	2	15	28.29	94.5	7.6651	72.5726
2025	10	16	20	12	15	30.48	96.2	7.6651	77.977
2025	10	16	20	22	15	29.41	94.9	7.6651	75.4035
2025	10	16	20	32	15	29.6	96.6	7.6651	75.6609
2025	10	16	20	42	15	29.13	95.5	7.6712	74.6935
2025	10	16	20	52	15	29.09	98.1	7.6712	74.1784
2025	10	16	21	2	15	30.69	96.4	7.6651	78.4918
2025	10	16	21	12	15	29.8	94.6	7.6712	76.4965
2025	10	16	21	22	15	29.29	96.5	7.6712	74.9511
2025	10	16	21	32	15	28.58	98	7.6712	72.8906
2025	10	16	21	42	15	28.69	96.6	7.6712	73.4058
2025	10	16	21	52	15	28.63	97.2	7.6712	73.1482
2025	10	16	22	2	15	30.57	96	7.6712	78.2995
2025	10	16	22	12	15	29.14	95.7	7.6712	74.6936
2025	10	16	22	22	15	28.97	94	7.6712	74.4361
2025	10	16	22	32	15	28.69	94.6	7.6712	73.6634
2025	10	16	22	42	15	29.92	96.9	7.6712	76.4966
2025	10	16	22	52	15	29.39	96.4	7.6712	75.2088
2025	10	16	23	2	15	29.05	95.7	7.6712	74.4361
2025	10	16	23	12	15	29.47	96.2	7.6712	75.4664
2025	10	16	23	22	15	29.73	95.4	7.6712	76.2391
2025	10	16	23	32	15	29.01	96.9	7.6712	74.1786
2025	10	16	23	42	15	28.6	94.8	7.6712	73.4059
2025	10	16	23	52	15	28.46	96.1	7.6712	72.8908

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	17	0	2	15	29.94	97.3	7.6712	76.4967
2025	10	17	0	12	15	29.73	95.4	7.6712	76.2391
2025	10	17	0	22	15	28.72	95.2	7.6712	73.6635
2025	10	17	0	32	15	28.06	97.8	7.6712	71.6029
2025	10	17	0	42	15	30.02	96.9	7.6712	76.7542
2025	10	17	0	52	15	28.98	96.3	7.6712	74.1786
2025	10	17	1	2	15	29.39	96.4	7.6712	75.2088
2025	10	17	1	12	15	28.47	94	7.6712	73.1483
2025	10	17	1	22	15	29.2	94.7	7.6712	74.9512
2025	10	17	1	32	15	29.28	96.3	7.6712	74.9512
2025	10	17	1	42	15	28.96	95.9	7.6712	74.1785
2025	10	17	1	52	15	29.29	98	7.6712	74.6936
2025	10	17	2	2	15	27.92	95.3	7.6712	71.6029
2025	10	17	2	12	15	28.11	95.1	7.6712	72.118
2025	10	17	2	22	15	28.82	95.2	7.6712	73.9209
2025	10	17	2	32	15	29.55	97.4	7.6712	75.4663
2025	10	17	2	42	15	28.69	96.6	7.6712	73.4058
2025	10	17	2	52	15	28.84	97.4	7.6773	73.7245
2025	10	17	3	2	15	28.75	95.8	7.6773	73.7245
2025	10	17	3	12	15	29.07	96.1	7.6773	74.4978
2025	10	17	3	22	15	27.73	92.5	7.6773	71.4044
2025	10	17	3	32	15	28.75	95.8	7.6773	73.7244
2025	10	17	3	42	15	28.66	96	7.6773	73.4666
2025	10	17	3	52	15	29.01	94.9	7.6773	74.4977
2025	10	17	4	2	15	28.91	98.4	7.6773	73.7244
2025	10	17	4	12	15	28.96	95.9	7.6773	74.24
2025	10	17	4	22	15	28.99	96.5	7.6773	74.24
2025	10	17	4	32	15	28.99	96.5	7.6773	74.2399
2025	10	17	4	42	15	29.2	94.7	7.6773	75.0133
2025	10	17	4	52	15	29.53	95.4	7.6773	75.7866
2025	10	17	5	2	15	28.13	97.4	7.6773	71.9199
2025	10	17	5	12	15	28.94	95.6	7.6773	74.2399
2025	10	17	5	22	15	27.94	95.8	7.6773	71.6621
2025	10	17	5	32	15	29.27	97.9	7.6773	74.7555
2025	10	17	5	42	15	28.3	96.9	7.6773	72.4355
2025	10	17	5	52	15	28.48	96.5	7.6773	72.951
2025	10	17	6	2	15	29.91	98.3	7.6773	76.3021
2025	10	17	6	12	15	28.35	95.9	7.6773	72.6932
2025	10	17	6	22	15	28.61	95	7.6773	73.4666
2025	10	17	6	32	15	28.98	96.3	7.6773	74.2399
2025	10	17	6	42	15	28.18	94.3	7.6773	72.4355
2025	10	17	6	52	15	28.9	96.8	7.6773	73.9821
2025	10	17	7	2	15	30.55	97.3	7.6773	78.1066
2025	10	17	7	12	15	28.84	95.6	7.6773	73.9821
2025	10	17	7	22	15	27.88	94.3	7.6773	71.6621
2025	10	17	7	32	15	28.6	94.8	7.6834	73.5275
2025	10	17	7	42	15	28.63	95.4	7.6834	73.5275
2025	10	17	7	52	15	29.22	95.3	7.6773	75.0133

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	17	8	2	15	27.5	95	7.6834	70.6896
2025	10	17	8	12	15	28.88	94.4	7.6834	74.3015
2025	10	17	8	22	15	29.13	95.3	7.6834	74.8175
2025	10	17	8	32	15	28.29	94.5	7.6834	72.7536
2025	10	17	8	42	15	29.13	95.5	7.6834	74.8175
2025	10	17	8	52	15	28.33	95.5	7.6834	72.7535
2025	10	17	9	2	15	28.04	95.7	7.6834	71.9795
2025	10	17	9	12	15	28.07	96.3	7.6834	71.9794
2025	10	17	9	22	15	29.29	94.5	7.6895	75.3957
2025	10	17	9	32	15	27.08	94.4	7.6895	69.7152
2025	10	17	9	42	15	27.48	94.4	7.6895	70.748
2025	10	17	9	52	15	28.67	94	7.6895	73.8464
2025	10	17	10	2	15	27.97	94.1	7.6895	72.039
2025	10	17	10	12	15	28.08	94.3	7.6895	72.2971
2025	10	17	10	22	15	28.44	95.7	7.6895	73.0717
2025	10	17	10	32	15	28.52	95.2	7.6895	73.3299
2025	10	17	10	42	15	28.03	95.5	7.6956	72.0985
2025	10	17	10	52	15	29.56	96	7.6895	75.9119
2025	10	17	11	2	15	27.88	94.3	7.6956	71.8401
2025	10	17	11	12	15	28.49	96.7	7.6895	73.0716
2025	10	17	11	22	15	27.74	95.8	7.6895	71.2642
2025	10	17	11	32	15	29.07	93.9	7.6956	74.941
2025	10	17	11	42	15	28.69	94.6	7.6956	73.9073
2025	10	17	11	52	15	27.86	93.7	7.6956	71.84
2025	10	17	12	2	15	28.49	94.6	7.6956	73.3904
2025	10	17	12	12	15	29.13	95.3	7.6956	74.9409
2025	10	17	12	22	15	29.16	97.7	7.6956	74.6825
2025	10	17	12	32	15	29.3	94.7	7.6956	75.4577
2025	10	17	12	42	15	28.55	95.8	7.6956	73.3904
2025	10	17	12	52	15	28.43	92.6	7.6956	73.3904
2025	10	17	13	2	15	29.34	95.7	7.6956	75.4577
2025	10	17	13	12	15	28.05	95.9	7.6956	72.0983
2025	10	17	13	22	15	29.07	93.9	7.6956	74.9408
2025	10	17	13	32	15	28.71	95	7.7017	73.9683
2025	10	17	13	42	15	28.38	94.2	7.6956	73.1319
2025	10	17	13	52	15	28.83	95.4	7.6956	74.1656
2025	10	17	14	2	15	28.65	93.4	7.6956	73.9072
2025	10	17	14	12	15	28.53	95.4	7.7017	73.4511
2025	10	17	14	22	15	28.49	94.6	7.7017	73.4511
2025	10	17	14	32	15	28.6	96.8	7.7017	73.4511
2025	10	17	14	42	15	28.56	96	7.6956	73.3903
2025	10	17	14	52	15	28.74	95.6	7.6956	73.9072
2025	10	17	15	2	15	28.89	94.6	7.7017	74.4856
2025	10	17	15	12	15	28.85	95.8	7.6956	74.1656
2025	10	17	15	22	15	28.68	96.4	7.7017	73.7097
2025	10	17	15	32	15	29.14	95.7	7.6956	74.9409
2025	10	17	15	42	15	29.1	96.7	7.6956	74.6825
2025	10	17	15	52	15	28.3	94.9	7.6956	72.8736

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	17	16	2	15	27.79	94.5	7.6956	71.5815
2025	10	17	16	12	15	28.94	95.6	7.6956	74.4241
2025	10	17	16	22	15	28.29	96.7	7.6956	72.6152
2025	10	17	16	32	15	29.45	97.4	7.6956	75.4578
2025	10	17	16	42	15	28.85	95.8	7.6956	74.1657
2025	10	17	16	52	15	27.48	96.5	7.6895	70.4896
2025	10	17	17	2	15	28.47	96.3	7.6956	73.1321
2025	10	17	17	12	15	28.6	94.8	7.6956	73.649
2025	10	17	17	22	15	28.49	96.7	7.6956	73.1321
2025	10	17	17	32	15	28.29	96.7	7.6956	72.6153
2025	10	17	17	42	15	29.24	95.7	7.6956	75.1995
2025	10	17	17	52	15	28.44	95.7	7.6956	73.1322
2025	10	17	18	2	15	29.26	96.1	7.6956	75.1995
2025	10	17	18	12	15	29.6	96.6	7.6956	75.9748
2025	10	17	18	22	15	27.81	97	7.6956	71.3233
2025	10	17	18	32	15	29.57	93.9	7.6956	76.2332
2025	10	17	18	42	15	29.04	95.5	7.6956	74.6828
2025	10	17	18	52	15	28.54	97.4	7.6956	73.1323
2025	10	17	19	2	15	28.98	96.3	7.6956	74.4244
2025	10	17	19	12	15	28.28	94.3	7.6956	72.8739
2025	10	17	19	22	15	29.4	96.6	7.6956	75.4581
2025	10	17	19	32	15	28.95	95.7	7.6956	74.4244
2025	10	17	19	42	15	29.01	94.9	7.6956	74.6829
2025	10	17	19	52	15	30.08	96.3	7.6956	77.2671
2025	10	17	20	2	15	30.06	95.9	7.6956	77.2671
2025	10	17	20	12	15	29.83	95.4	7.6956	76.7503
2025	10	17	20	22	15	28.22	97.1	7.6956	72.3572
2025	10	17	20	32	15	29.45	95.8	7.6956	75.7167
2025	10	17	20	42	15	29.65	95.8	7.6956	76.2335
2025	10	17	20	52	15	28.99	96.5	7.6956	74.4246
2025	10	17	21	2	15	27.45	96.1	7.6956	70.5483
2025	10	17	21	12	15	28.05	93.5	7.6956	72.3573
2025	10	17	21	22	15	28.4	94.8	7.6956	73.1326
2025	10	17	21	32	15	30.05	97.5	7.6895	76.9452
2025	10	17	21	42	15	29.13	95.5	7.6956	74.9415
2025	10	17	21	52	15	28.63	95.4	7.6956	73.6494
2025	10	17	22	2	15	28.68	96.4	7.6956	73.6495
2025	10	17	22	12	15	28.36	96.1	7.6956	72.8742
2025	10	17	22	22	15	29.43	95.5	7.6956	75.7168
2025	10	17	22	32	15	29.78	97.9	7.6956	76.2337
2025	10	17	22	42	15	28.75	95.8	7.6956	73.9079
2025	10	17	22	52	15	28.84	95.6	7.6895	74.105
2025	10	17	23	2	15	29.48	94.3	7.6956	75.9753
2025	10	17	23	12	15	29.13	95.5	7.6956	74.9416
2025	10	17	23	22	15	29.21	96.9	7.6956	74.9416
2025	10	17	23	32	15	29.19	96.5	7.6895	74.8796
2025	10	17	23	42	15	29.63	97.2	7.6956	75.9753
2025	10	17	23	52	15	30.13	95.3	7.6956	77.5258

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	18	0	2	15	29.07	96.1	7.6895	74.6215
2025	10	18	0	12	15	29.09	96.5	7.6956	74.6833
2025	10	18	0	22	15	29.09	96.5	7.6895	74.6215
2025	10	18	0	32	15	30.4	96.6	7.6895	77.9781
2025	10	18	0	42	15	29.83	97.1	7.6895	76.4289
2025	10	18	0	52	15	29.42	97	7.6895	75.3961
2025	10	18	1	2	15	29.19	96.5	7.6895	74.8797
2025	10	18	1	12	15	27.91	95.1	7.6895	71.7812
2025	10	18	1	22	15	28.46	96.1	7.6895	73.0722
2025	10	18	1	32	15	29.34	95.7	7.6895	75.3961
2025	10	18	1	42	15	28.74	95.6	7.6895	73.8468
2025	10	18	1	52	15	29.42	95.3	7.6895	75.6543
2025	10	18	2	2	15	28.93	95.4	7.6895	74.3633
2025	10	18	2	12	15	29.9	94.8	7.6895	76.9453
2025	10	18	2	22	15	28.37	96.3	7.6895	72.814
2025	10	18	2	32	15	28.93	95.4	7.6895	74.3632
2025	10	18	2	42	15	26.98	96.6	7.6895	69.1991
2025	10	18	2	52	15	29.04	95.5	7.6895	74.6215
2025	10	18	3	2	15	28.06	93.9	7.6895	72.2976
2025	10	18	3	12	15	29.34	95.7	7.6895	75.3961
2025	10	18	3	22	15	29.59	94.5	7.6895	76.1707
2025	10	18	3	32	15	28.66	96	7.6895	73.5886
2025	10	18	3	42	15	28.71	97	7.6895	73.5886
2025	10	18	3	52	15	29.95	95.7	7.6895	76.9453
2025	10	18	4	2	15	28.46	96.1	7.6834	73.0117
2025	10	18	4	12	15	29.64	95.6	7.6895	76.1707
2025	10	18	4	22	15	28.73	95.4	7.6895	73.8468
2025	10	18	4	32	15	28.69	94.6	7.6895	73.8468
2025	10	18	4	42	15	28.97	94	7.6895	74.6214
2025	10	18	4	52	15	30.27	96.1	7.6895	77.7199
2025	10	18	5	2	15	29.72	97	7.6834	76.1076
2025	10	18	5	12	15	28.89	96.6	7.6834	74.0437
2025	10	18	5	22	15	28.99	94.6	7.6834	74.5596
2025	10	18	5	32	15	28.34	95.7	7.6895	72.814
2025	10	18	5	42	15	29.72	97	7.6895	76.1707
2025	10	18	5	52	15	28.67	96.2	7.6895	73.5886
2025	10	18	6	2	15	29.22	95.3	7.6834	75.0757
2025	10	18	6	12	15	29.57	96.2	7.6834	75.8496
2025	10	18	6	22	15	29.16	97.7	7.6834	74.5597
2025	10	18	6	32	15	28.94	95.6	7.6834	74.3017
2025	10	18	6	42	15	29.98	94.2	7.6834	77.1396
2025	10	18	6	52	15	28.43	98.7	7.6834	72.4958
2025	10	18	7	2	15	27.7	94.8	7.6834	71.2058
2025	10	18	7	12	15	28.34	95.7	7.6834	72.7538
2025	10	18	7	22	15	29.1	96.7	7.6834	74.5597
2025	10	18	7	32	15	29.61	96.8	7.6834	75.8497
2025	10	18	7	42	15	29.09	96.5	7.6834	74.5597
2025	10	18	7	52	15	28.61	95	7.6834	73.5278

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	18	8	2	15	29.51	96.8	7.6834	75.5917
2025	10	18	8	12	15	29.47	96.2	7.6834	75.5917
2025	10	18	8	22	15	29.23	95.5	7.6834	75.0758
2025	10	18	8	32	15	28.32	95.3	7.6834	72.7538
2025	10	18	8	42	15	29.04	95.5	7.6834	74.5598
2025	10	18	8	52	15	28.69	96.6	7.6834	73.5277
2025	10	18	9	2	15	29.6	94.7	7.6834	76.1076
2025	10	18	9	12	15	28.09	96.7	7.6834	71.9797
2025	10	18	9	22	15	28.74	95.6	7.6834	73.7856
2025	10	18	9	32	15	28.53	92.8	7.6834	73.5276
2025	10	18	9	42	15	28.39	94.4	7.6834	73.0116
2025	10	18	9	52	15	28.9	94.8	7.6834	74.3015
2025	10	18	10	2	15	29.04	95.5	7.6834	74.5595
2025	10	18	10	12	15	28.36	93.6	7.6834	73.0115
2025	10	18	10	22	15	27.64	93.1	7.6834	71.2055
2025	10	18	10	32	15	28.18	94.3	7.6834	72.4954
2025	10	18	10	42	15	27.54	93.1	7.6834	70.9475
2025	10	18	10	52	15	28.51	95	7.6834	73.2694
2025	10	18	11	2	15	28.59	96.6	7.6834	73.2693
2025	10	18	11	12	15	28.29	96.7	7.6834	72.4953
2025	10	18	11	22	15	28.79	94.6	7.6834	74.0433
2025	10	18	11	32	15	29.77	93.9	7.6834	76.6231
2025	10	18	11	42	15	29.23	95.5	7.6834	75.0751
2025	10	18	11	52	15	29.26	93.7	7.6834	75.3331
2025	10	18	12	2	15	28.85	95.8	7.6834	74.0432
2025	10	18	12	12	15	28.91	97	7.6834	74.0431
2025	10	18	12	22	15	27.81	95.2	7.6834	71.4632
2025	10	18	12	32	15	28.68	94.2	7.6834	73.7851
2025	10	18	12	42	15	28.27	96.3	7.6773	72.435
2025	10	18	12	52	15	27.42	95.4	7.6773	70.3728
2025	10	18	13	2	15	28.06	96.1	7.6773	71.9195
2025	10	18	13	12	15	27.59	94.6	7.6773	70.8883
2025	10	18	13	22	15	28.5	94.8	7.6773	73.2083
2025	10	18	13	32	15	27.42	95.4	7.6712	70.3144
2025	10	18	13	42	15	28.46	93.8	7.6773	73.2083
2025	10	18	13	52	15	27.92	95.3	7.6712	71.6022
2025	10	18	14	2	15	27.75	97.7	7.6651	70.7708
2025	10	18	14	12	15	29.15	95.9	7.6712	74.693
2025	10	18	14	22	15	28.39	96.7	7.6712	72.6325
2025	10	18	14	32	15	28.94	95.6	7.6651	74.1163
2025	10	18	14	42	15	28.14	95.7	7.6651	72.0575
2025	10	18	14	52	15	27.88	94.3	7.6712	71.6022
2025	10	18	15	2	15	29.24	97.3	7.6651	74.631
2025	10	18	15	12	15	28.75	97.6	7.6651	73.3442
2025	10	18	15	22	15	28.03	97.4	7.6651	71.5428
2025	10	18	15	32	15	27.96	93.9	7.659	71.7405
2025	10	18	15	42	15	29.13	95.3	7.6529	74.507
2025	10	18	15	52	15	28.27	96.3	7.6529	72.1947

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	18	16	2	15	28.85	95.8	7.6529	73.7363
2025	10	18	16	12	15	28.69	94.6	7.6529	73.4794
2025	10	18	16	22	15	28.85	95.8	7.6529	73.7363
2025	10	18	16	32	15	28.49	96.7	7.6468	72.6482
2025	10	18	16	42	15	28.69	94.6	7.6468	73.4183
2025	10	18	16	52	15	27.63	95.6	7.6468	70.5946
2025	10	18	17	2	15	28.47	96.3	7.6407	72.5877
2025	10	18	17	12	15	28.05	95.9	7.6407	71.5618
2025	10	18	17	22	15	28.75	95.8	7.6346	73.2961
2025	10	18	17	32	15	29.68	96.4	7.6346	75.6026
2025	10	18	17	42	15	28.46	96.1	7.6346	72.5273
2025	10	18	17	52	15	29.4	98.2	7.6346	74.5775
2025	10	18	18	2	15	28.43	95.4	7.6346	72.5273
2025	10	18	18	12	15	29.51	95.1	7.6346	75.3464
2025	10	18	18	22	15	29.42	97	7.6285	74.7714
2025	10	18	18	32	15	29.01	96.9	7.6285	73.7472
2025	10	18	18	42	15	29.13	95.3	7.6285	74.2593
2025	10	18	18	52	15	29.29	96.5	7.6285	74.5154
2025	10	18	19	2	15	30.39	96.4	7.6285	77.3322
2025	10	18	19	12	15	29.45	95.8	7.6285	75.0276
2025	10	18	19	22	15	29.21	94.9	7.6285	74.5155
2025	10	18	19	32	15	29.42	97	7.6285	74.7716
2025	10	18	19	42	15	27.98	94.3	7.6224	71.3831
2025	10	18	19	52	15	28.98	96.3	7.6224	73.6858
2025	10	18	20	2	15	27.56	96.2	7.6224	70.1038
2025	10	18	20	12	15	28.22	95.3	7.6224	71.8948
2025	10	18	20	22	15	28.54	95.6	7.6224	72.6624
2025	10	18	20	32	15	27.92	95.3	7.6224	71.1273
2025	10	18	20	42	15	28.85	97.6	7.6224	73.1742
2025	10	18	20	52	15	28.4	94.8	7.6224	72.4066
2025	10	18	21	2	15	29.25	95.9	7.6224	74.4535
2025	10	18	21	12	15	28.79	96.6	7.6224	73.1742
2025	10	18	21	22	15	28.78	96.4	7.6163	73.1131
2025	10	18	21	32	15	28.18	96.5	7.6163	71.5793
2025	10	18	21	42	15	28.06	97.8	7.6163	71.068
2025	10	18	21	52	15	29.81	96.7	7.6163	75.6695
2025	10	18	22	2	15	29.18	96.3	7.6163	74.1357
2025	10	18	22	12	15	28.68	96.4	7.6163	72.8575
2025	10	18	22	22	15	29.28	96.3	7.6163	74.3914
2025	10	18	22	32	15	28.21	95.1	7.6163	71.835
2025	10	18	22	42	15	28.34	97.5	7.6102	71.7749
2025	10	18	22	52	15	29.01	94.9	7.6102	73.8184
2025	10	18	23	2	15	29.53	97.2	7.6102	74.8401
2025	10	18	23	12	15	29.21	99.7	7.6102	73.5629
2025	10	18	23	22	15	28.84	97.4	7.6102	73.0521
2025	10	18	23	32	15	29.08	97.9	7.6102	73.5629
2025	10	18	23	42	15	29.93	97.1	7.6102	75.8618
2025	10	18	23	52	15	28.25	95.9	7.6102	71.775

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	19	0	2	15	29.47	96.2	7.6102	74.8401
2025	10	19	0	12	15	28.68	96.4	7.6102	72.7967
2025	10	19	0	22	15	28.54	95.6	7.6041	72.4805
2025	10	19	0	32	15	27.71	95.2	7.6102	70.4978
2025	10	19	0	42	15	28.66	96	7.6102	72.7967
2025	10	19	0	52	15	30.43	97	7.6041	77.0744
2025	10	19	1	2	15	28.69	94.6	7.6102	73.0521
2025	10	19	1	12	15	29.53	97.2	7.6102	74.8401
2025	10	19	1	22	15	29.58	96.4	7.6041	75.0327
2025	10	19	1	32	15	28.13	97.4	7.6041	71.2045
2025	10	19	1	42	15	28.29	94.7	7.6041	71.9701
2025	10	19	1	52	15	28.24	95.7	7.6041	71.7149
2025	10	19	2	2	15	29.83	97.1	7.6041	75.5431
2025	10	19	2	12	15	29.98	96.3	7.6041	76.0535
2025	10	19	2	22	15	27.43	95.6	7.6041	69.6732
2025	10	19	2	32	15	27.8	95	7.6041	70.694
2025	10	19	2	42	15	28.84	97.4	7.6041	72.9909
2025	10	19	2	52	15	29.09	98.1	7.6041	73.5013
2025	10	19	3	2	15	28.13	95.5	7.6041	71.4596
2025	10	19	3	12	15	29.29	96.5	7.6041	74.2669
2025	10	19	3	22	15	29.6	96.6	7.6041	75.0326
2025	10	19	3	32	15	28.31	95.1	7.6041	71.97
2025	10	19	3	42	15	29.41	94.9	7.6041	74.7773
2025	10	19	3	52	15	29.41	94.9	7.6041	74.7773
2025	10	19	4	2	15	29.7	96.6	7.6041	75.2877
2025	10	19	4	12	15	28.78	96.4	7.6041	72.9908
2025	10	19	4	22	15	28.69	96.6	7.6041	72.7356
2025	10	19	4	32	15	28.86	97.8	7.6041	72.9908
2025	10	19	4	42	15	27.63	95.6	7.6041	70.1835
2025	10	19	4	52	15	29.04	95.5	7.6041	73.7565
2025	10	19	5	2	15	28.51	95	7.6041	72.4804
2025	10	19	5	12	15	29.39	96.4	7.6041	74.5221
2025	10	19	5	22	15	29.42	95.3	7.6041	74.7773
2025	10	19	5	32	15	29.21	94.9	7.5981	74.2047
2025	10	19	5	42	15	28.43	97.3	7.5981	71.9097
2025	10	19	5	52	15	29.15	95.9	7.5981	73.9497
2025	10	19	6	2	15	28.43	95.4	7.5981	72.1647
2025	10	19	6	12	15	28.75	97.6	7.5981	72.6746
2025	10	19	6	22	15	29.05	97.5	7.5981	73.4397
2025	10	19	6	32	15	28.81	97	7.5981	72.9296
2025	10	19	6	42	15	28.06	97.8	7.5981	70.8896
2025	10	19	6	52	15	28.38	96.5	7.5981	71.9097
2025	10	19	7	2	15	27.93	95.5	7.5981	70.8897
2025	10	19	7	12	15	29.28	94.1	7.5981	74.4596
2025	10	19	7	22	15	27.44	95.9	7.5981	69.6147
2025	10	19	7	32	15	28.02	95.3	7.5981	71.1447
2025	10	19	7	42	15	28.9	96.8	7.5981	73.1847
2025	10	19	7	52	15	29.05	95.7	7.5981	73.6947

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	19	8	2	15	29.19	96.5	7.5981	73.9497
2025	10	19	8	12	15	27.94	95.8	7.5981	70.8897
2025	10	19	8	22	15	27.85	96	7.5981	70.6347
2025	10	19	8	32	15	28.43	95.4	7.5981	72.1647
2025	10	19	8	42	15	27.52	95.4	7.5981	69.8697
2025	10	19	8	52	15	28.36	96.1	7.5981	71.9096
2025	10	19	9	2	15	29.09	96.5	7.5981	73.6945
2025	10	19	9	12	15	28.35	95.9	7.5981	71.9095
2025	10	19	9	22	15	28.76	96	7.5981	72.9295
2025	10	19	9	32	15	28.39	94.6	7.5981	72.1644
2025	10	19	9	42	15	29.35	97.4	7.5981	74.2044
2025	10	19	9	52	15	28.85	95.8	7.5981	73.1843
2025	10	19	10	2	15	28.65	93.4	7.5981	72.9293
2025	10	19	10	12	15	27.81	97	7.5981	70.3793
2025	10	19	10	22	15	28.41	95	7.5981	72.1642
2025	10	19	10	32	15	27.58	98.1	7.5981	69.6142
2025	10	19	10	42	15	28.91	95	7.5981	73.4392
2025	10	19	10	52	15	29.26	96.1	7.5981	74.2041
2025	10	19	11	2	15	28.91	98.4	7.5981	72.9291
2025	10	19	11	12	15	29.25	97.5	7.5981	73.9491
2025	10	19	11	22	15	28.74	95.6	7.5981	72.929
2025	10	19	11	32	15	27.17	94	7.5981	69.1041
2025	10	19	11	42	15	27.6	94.8	7.5981	70.124
2025	10	19	11	52	15	28.94	95.6	7.592	73.3774
2025	10	19	12	2	15	28.61	97	7.592	72.3582
2025	10	19	12	12	15	26.69	94.7	7.5798	67.6584
2025	10	19	12	22	15	27.75	93.5	7.5859	70.5155
2025	10	19	12	32	15	27.85	93.5	7.5859	70.77
2025	10	19	12	42	15	27.81	95.2	7.5859	70.5155
2025	10	19	12	52	15	28.56	93.8	7.5798	72.4911
2025	10	19	13	2	15	27.78	96.6	7.5798	70.2019
2025	10	19	13	12	15	27.28	94.4	7.5798	69.1844
2025	10	19	13	22	15	28.33	95.5	7.5798	71.728
2025	10	19	13	32	15	26.55	93.7	7.5798	67.4039
2025	10	19	13	42	15	27.37	94.2	7.5737	69.3804
2025	10	19	13	52	15	27.84	95.8	7.5798	70.4562
2025	10	19	14	2	15	28.98	94.2	7.5737	73.4467
2025	10	19	14	12	15	27.85	93.5	7.5737	70.6512
2025	10	19	14	22	15	26.93	95.5	7.5676	68.0525
2025	10	19	14	32	15	28.21	95.1	7.5676	71.3535
2025	10	19	14	42	15	29.07	96.1	7.5676	73.3849
2025	10	19	14	52	15	26.77	96.4	7.5676	67.5446
2025	10	19	15	2	15	28.21	95.1	7.5676	71.3536
2025	10	19	15	12	15	27.67	93.9	7.5676	70.0839
2025	10	19	15	22	15	27.85	96	7.5615	70.2787
2025	10	19	15	32	15	27.77	96.4	7.5615	70.025
2025	10	19	15	42	15	27.6	94.8	7.5615	69.7712
2025	10	19	15	52	15	27.8	95	7.5615	70.2787

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	19	16	2	15	28.59	96.6	7.5615	72.0547
2025	10	19	16	12	15	28.22	95.3	7.5615	71.2935
2025	10	19	16	22	15	29.04	97.3	7.5615	73.0696
2025	10	19	16	32	15	27.1	94.9	7.5615	68.5028
2025	10	19	16	42	15	28.38	96.5	7.5615	71.5473
2025	10	19	16	52	15	27.88	96.6	7.5615	70.2788
2025	10	19	17	2	15	28.55	95.8	7.5554	71.9941
2025	10	19	17	12	15	28.24	97.5	7.5554	70.9801
2025	10	19	17	22	15	28.01	97	7.5615	70.5325
2025	10	19	17	32	15	28.23	97.3	7.5554	70.9801
2025	10	19	17	42	15	28.38	96.5	7.5554	71.4871
2025	10	19	17	52	15	29.6	96.6	7.5554	74.5291
2025	10	19	18	2	15	28.23	97.3	7.5554	70.9802
2025	10	19	18	12	15	27.91	95.1	7.5554	70.4732
2025	10	19	18	22	15	28.79	96.6	7.5554	72.5012
2025	10	19	18	32	15	28.26	93.9	7.5554	71.4872
2025	10	19	18	42	15	28.18	94.3	7.5554	71.2337
2025	10	19	18	52	15	27.37	94.2	7.5554	69.2057
2025	10	19	19	2	15	28.48	98.1	7.5554	71.4873
2025	10	19	19	12	15	28.77	94	7.5554	72.7548
2025	10	19	19	22	15	27.97	96.4	7.5554	70.4733
2025	10	19	19	32	15	28.57	97.8	7.5554	71.7408
2025	10	19	19	42	15	27.98	94.3	7.5554	70.7268
2025	10	19	19	52	15	30.27	97.6	7.5554	76.0504
2025	10	19	20	2	15	28.27	96.3	7.5554	71.2339
2025	10	19	20	12	15	28.04	95.7	7.5554	70.7269
2025	10	19	20	22	15	29.51	96.8	7.5554	74.2759
2025	10	19	20	32	15	29.35	97.4	7.5554	73.769
2025	10	19	20	42	15	29.19	94.5	7.5554	73.769
2025	10	19	20	52	15	29.73	95.4	7.5554	75.0365
2025	10	19	21	2	15	28.77	96.2	7.5554	72.5015
2025	10	19	21	12	15	28.9	94.8	7.5554	73.0085
2025	10	19	21	22	15	29.02	99.7	7.5493	72.4404
2025	10	19	21	32	15	28.49	96.7	7.5493	71.6806
2025	10	19	21	42	15	28.14	93.1	7.5493	71.174
2025	10	19	21	52	15	28.4	96.9	7.5493	71.4273
2025	10	19	22	2	15	28.81	95	7.5493	72.6938
2025	10	19	22	12	15	29.29	94.5	7.5493	73.9602
2025	10	19	22	22	15	28.94	95.6	7.5493	72.9471
2025	10	19	22	32	15	27.44	95.9	7.5554	69.2061
2025	10	19	22	42	15	28.61	95	7.5493	72.1872
2025	10	19	22	52	15	29.01	96.9	7.5493	72.9471
2025	10	19	23	2	15	28.43	97.3	7.5493	71.4274
2025	10	19	23	12	15	27.55	96	7.5493	69.4011
2025	10	19	23	22	15	28.94	95.6	7.5493	72.9471
2025	10	19	23	32	15	28.18	96.5	7.5493	70.9208
2025	10	19	23	42	15	29.19	96.5	7.5493	73.4537
2025	10	19	23	52	15	27.36	93.8	7.5493	69.1478

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	20	0	2	15	28.94	95.6	7.5493	72.9472
2025	10	20	0	12	15	27.02	95.3	7.5493	68.1347
2025	10	20	0	22	15	28.21	95.1	7.5493	71.1741
2025	10	20	0	32	15	29.25	95.9	7.5493	73.707
2025	10	20	0	42	15	29.54	95.6	7.5493	74.4669
2025	10	20	0	52	15	27.83	95.6	7.5493	70.161
2025	10	20	1	2	15	27.12	95.3	7.5493	68.3879
2025	10	20	1	12	15	28.83	95.4	7.5493	72.6938
2025	10	20	1	22	15	28.05	95.9	7.5493	70.6675
2025	10	20	1	32	15	29.56	96	7.5493	74.4669
2025	10	20	1	42	15	27.31	95	7.5493	68.8945
2025	10	20	1	52	15	28.68	96.4	7.5493	72.1872
2025	10	20	2	2	15	28.05	95.9	7.5493	70.6675
2025	10	20	2	12	15	28.52	95.2	7.5493	71.9339
2025	10	20	2	22	15	28.44	97.5	7.5493	71.4273
2025	10	20	2	32	15	28.02	95.3	7.5493	70.6675
2025	10	20	2	42	15	27.79	94.5	7.5493	70.1609
2025	10	20	2	52	15	28.71	95	7.5493	72.4405
2025	10	20	3	2	15	28.54	95.6	7.5493	71.9339
2025	10	20	3	12	15	28.84	97.4	7.5493	72.4405
2025	10	20	3	22	15	28.07	96.3	7.5493	70.6674
2025	10	20	3	32	15	27.55	96	7.5493	69.401
2025	10	20	3	42	15	29.23	95.5	7.5493	73.7069
2025	10	20	3	52	15	28.29	94.5	7.5493	71.4273
2025	10	20	4	2	15	28.79	96.6	7.5493	72.4404
2025	10	20	4	12	15	28.31	95.1	7.5493	71.4273
2025	10	20	4	22	15	27.94	95.8	7.5493	70.4141
2025	10	20	4	32	15	27.2	94.9	7.5493	68.6411
2025	10	20	4	42	15	27.94	95.8	7.5493	70.4141
2025	10	20	4	52	15	28.22	95.3	7.5493	71.1739
2025	10	20	5	2	15	28.69	96.6	7.5493	72.1871
2025	10	20	5	12	15	28.95	95.7	7.5493	72.947
2025	10	20	5	22	15	27.92	95.3	7.5493	70.4141
2025	10	20	5	32	15	28.58	94.4	7.5493	72.1871
2025	10	20	5	42	15	28.9	94.8	7.5493	72.9469
2025	10	20	5	52	15	28.85	95.8	7.5493	72.6936
2025	10	20	6	2	15	27.81	95.2	7.5493	70.1608
2025	10	20	6	12	15	27.33	97.4	7.5493	68.641
2025	10	20	6	22	15	28.38	94.2	7.5493	71.6805
2025	10	20	6	32	15	28.24	95.7	7.5493	71.1739
2025	10	20	6	42	15	26.82	95.3	7.5493	67.6279
2025	10	20	6	52	15	27.07	96.4	7.5493	68.1345
2025	10	20	7	2	15	28.46	93.6	7.5493	71.9338
2025	10	20	7	12	15	28.12	97.2	7.5493	70.6673
2025	10	20	7	22	15	27.8	96.8	7.5432	69.8485
2025	10	20	7	32	15	27.22	95.3	7.5493	68.641
2025	10	20	7	42	15	29.62	97	7.5493	74.4667
2025	10	20	7	52	15	28.82	95.2	7.5432	72.6323

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	20	8	2	15	27.6	95	7.5432	69.5954
2025	10	20	8	12	15	29.23	95.5	7.5432	73.6446
2025	10	20	8	22	15	28.72	95.2	7.5493	72.4404
2025	10	20	8	32	15	27.64	95.8	7.5493	69.6542
2025	10	20	8	42	15	29.71	95	7.5493	74.9732
2025	10	20	8	52	15	28.04	95.7	7.5493	70.6673
2025	10	20	9	2	15	27.69	96.6	7.5493	69.6541
2025	10	20	9	12	15	27.96	93.7	7.5493	70.6672
2025	10	20	9	22	15	28.96	95.9	7.5493	72.9468
2025	10	20	9	32	15	27.61	95.2	7.5493	69.654
2025	10	20	9	42	15	29.68	96.4	7.5493	74.7197
2025	10	20	9	52	15	28.36	96.1	7.5493	71.4269
2025	10	20	10	2	15	27.01	95.1	7.5493	68.1342
2025	10	20	10	12	15	27.88	94.3	7.5493	70.4137
2025	10	20	10	22	15	28.58	94.2	7.5493	72.1867
2025	10	20	10	32	15	28.98	94.4	7.5493	73.1998
2025	10	20	10	42	15	28.26	96.1	7.5493	71.1735
2025	10	20	10	52	15	27.8	95	7.5493	70.1603
2025	10	20	11	2	15	28.33	97.3	7.5554	71.2335
2025	10	20	11	12	15	27.58	94.4	7.5554	69.7125
2025	10	20	11	22	15	27.32	95.5	7.5493	68.8938
2025	10	20	11	32	15	28.8	96.8	7.5554	72.5009
2025	10	20	11	42	15	28.21	98.6	7.5493	70.6668
2025	10	20	11	52	15	27.85	96	7.5554	70.2194
2025	10	20	12	2	15	29.1	96.7	7.5554	73.2614
2025	10	20	12	12	15	28.3	94.9	7.5554	71.4868
2025	10	20	12	22	15	28.9	96.8	7.5554	72.7543
2025	10	20	12	32	15	28.61	95	7.5554	72.2473
2025	10	20	12	42	15	28.8	96.8	7.5554	72.5007
2025	10	20	12	52	15	28.66	96	7.5554	72.2472
2025	10	20	13	2	15	28.59	96.6	7.5554	71.9937
2025	10	20	13	12	15	28.45	95.9	7.5554	71.7402
2025	10	20	13	22	15	28.39	96.7	7.5554	71.4867
2025	10	20	13	32	15	28.45	95.9	7.5554	71.7402
2025	10	20	13	42	15	27.18	94.4	7.5554	68.6982
2025	10	20	13	52	15	27.44	95.9	7.5554	69.2051
2025	10	20	14	2	15	28.18	99.4	7.5554	70.4726
2025	10	20	14	12	15	28.4	96.9	7.5554	71.4866
2025	10	20	14	22	15	29.22	97.1	7.5554	73.5146
2025	10	20	14	32	15	28.74	95.6	7.5493	72.4395
2025	10	20	14	42	15	27.87	96.4	7.5554	70.2192
2025	10	20	14	52	15	29.54	98.8	7.5554	74.0217
2025	10	20	15	2	15	28.77	96.2	7.5493	72.4395
2025	10	20	15	12	15	28.49	96.7	7.5554	71.7402
2025	10	20	15	22	15	28.39	96.7	7.5493	71.4264
2025	10	20	15	32	15	28.56	96	7.5493	71.933
2025	10	20	15	42	15	27.67	96.4	7.5493	69.6534
2025	10	20	15	52	15	27.83	95.6	7.5493	70.16

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	20	16	2	15	28.34	98.9	7.5493	70.9199
2025	10	20	16	12	15	27.23	95.7	7.5493	68.6404
2025	10	20	16	22	15	27.76	96.2	7.5493	69.9068
2025	10	20	16	32	15	28.91	98.4	7.5493	72.4397
2025	10	20	16	42	15	27.91	97	7.5493	70.1602
2025	10	20	16	52	15	28.38	96.5	7.5493	71.4266
2025	10	20	17	2	15	28.38	98.1	7.5493	71.1733
2025	10	20	17	12	15	28.99	96.5	7.5432	72.8848
2025	10	20	17	22	15	27.61	95.2	7.5432	69.5949
2025	10	20	17	32	15	28.99	98.1	7.5432	72.6317
2025	10	20	17	42	15	27.9	96.8	7.5432	70.101
2025	10	20	17	52	15	28.15	95.9	7.5432	70.8602
2025	10	20	18	2	15	28.22	95.3	7.5432	71.1133
2025	10	20	18	12	15	28.19	94.5	7.5432	71.1133
2025	10	20	18	22	15	27.88	94.3	7.5432	70.3541
2025	10	20	18	32	15	28.99	98.1	7.5432	72.6318
2025	10	20	18	42	15	28.24	95.7	7.5432	71.1134
2025	10	20	18	52	15	27.42	95.4	7.5432	69.0888
2025	10	20	19	2	15	29.43	97.2	7.5432	73.8972
2025	10	20	19	12	15	27.83	95.6	7.5432	70.1012
2025	10	20	19	22	15	28.5	96.9	7.5432	71.6196
2025	10	20	19	32	15	28.19	96.7	7.5432	70.8604
2025	10	20	19	42	15	28.29	94.5	7.5432	71.3666
2025	10	20	19	52	15	29.04	97.3	7.5432	72.885
2025	10	20	20	2	15	28.74	97.4	7.5432	72.1258
2025	10	20	20	12	15	28.56	96	7.5432	71.8728
2025	10	20	20	22	15	27.6	96.9	7.5432	69.3421
2025	10	20	20	32	15	28.19	94.7	7.5432	71.1136
2025	10	20	20	42	15	28.1	94.9	7.5432	70.8605
2025	10	20	20	52	15	29.22	95.1	7.5432	73.6444
2025	10	20	21	2	15	28.03	95.5	7.5432	70.6075
2025	10	20	21	12	15	28.49	96.7	7.5371	71.5593
2025	10	20	21	22	15	28.31	95.1	7.5371	71.3065
2025	10	20	21	32	15	28.49	96.7	7.5432	71.6199
2025	10	20	21	42	15	27.87	94.1	7.5432	70.3545
2025	10	20	21	52	15	28.8	94.8	7.5371	72.5708
2025	10	20	22	2	15	28.41	95	7.5371	71.5594
2025	10	20	22	12	15	28.9	96.8	7.5371	72.5709
2025	10	20	22	22	15	28.49	96.7	7.5371	71.5594
2025	10	20	22	32	15	29.04	95.5	7.5371	73.0766
2025	10	20	22	42	15	28.43	95.4	7.5371	71.5595
2025	10	20	22	52	15	28.09	96.7	7.5371	70.548
2025	10	20	23	2	15	28.95	97.5	7.5371	72.5709
2025	10	20	23	12	15	26.52	95.4	7.5371	66.7551
2025	10	20	23	22	15	29.39	96.4	7.5371	73.8353
2025	10	20	23	32	15	28.77	94	7.5371	72.571
2025	10	20	23	42	15	28.52	97.1	7.5371	71.5595
2025	10	20	23	52	15	27.48	94.4	7.5371	69.2838

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	21	0	2	15	28.31	98.5	7.5371	70.8009
2025	10	21	0	12	15	28.4	94.8	7.5371	71.5595
2025	10	21	0	22	15	28.13	95.5	7.5371	70.8009
2025	10	21	0	32	15	29.05	97.5	7.5371	72.8238
2025	10	21	0	42	15	28.09	96.7	7.5371	70.5481
2025	10	21	0	52	15	26.8	94.9	7.5371	67.5137
2025	10	21	1	2	15	27.91	95.1	7.5371	70.2952
2025	10	21	1	12	15	28.18	96.5	7.5371	70.8009
2025	10	21	1	22	15	27.97	96.4	7.5371	70.2952
2025	10	21	1	32	15	28.45	93.4	7.531	71.7517
2025	10	21	1	42	15	28.46	96.1	7.531	71.499
2025	10	21	1	52	15	27.33	97.4	7.5371	68.5252
2025	10	21	2	2	15	27.96	93.9	7.531	70.4884
2025	10	21	2	12	15	27.78	94.3	7.531	69.9831
2025	10	21	2	22	15	28.51	95	7.531	71.7516
2025	10	21	2	32	15	28.3	96.9	7.531	70.9937
2025	10	21	2	42	15	27.44	95.9	7.531	68.9725
2025	10	21	2	52	15	28.45	95.9	7.531	71.499
2025	10	21	3	2	15	28.74	95.6	7.531	72.2569
2025	10	21	3	12	15	28.33	95.5	7.531	71.2463
2025	10	21	3	22	15	27.33	92.7	7.531	68.9725
2025	10	21	3	32	15	27.5	95	7.531	69.2251
2025	10	21	3	42	15	28.16	96.1	7.5249	70.6812
2025	10	21	3	52	15	28.57	96.2	7.5249	71.6909
2025	10	21	4	2	15	27.71	95.2	7.5249	69.6714
2025	10	21	4	12	15	28.64	97.4	7.5249	71.6909
2025	10	21	4	22	15	27.89	94.7	7.5249	70.1763
2025	10	21	4	32	15	26.95	96	7.5249	67.6519
2025	10	21	4	42	15	27.22	95.5	7.5188	68.3513
2025	10	21	4	52	15	27.7	94.8	7.5188	69.6124
2025	10	21	5	2	15	29.11	94.9	7.5188	73.1435
2025	10	21	5	12	15	26.76	93.9	7.5188	67.3424
2025	10	21	5	22	15	27.04	97.7	7.5127	67.5374
2025	10	21	5	32	15	28.19	98.2	7.5188	70.369
2025	10	21	5	42	15	27.59	96.7	7.5188	69.1079
2025	10	21	5	52	15	28.28	94.3	7.5127	71.0654
2025	10	21	6	2	15	27.81	95.2	7.5066	69.7462
2025	10	21	6	12	15	27.7	96.8	7.5066	69.2426
2025	10	21	6	22	15	28.25	95.9	7.5005	70.6933
2025	10	21	6	32	15	27.59	96.7	7.4944	68.8737
2025	10	21	6	42	15	28.26	97.7	7.4944	70.3819
2025	10	21	6	52	15	28.29	96.7	7.4944	70.6333
2025	10	21	7	2	15	27.58	94.4	7.4944	69.1251
2025	10	21	7	12	15	28.19	96.7	7.4944	70.3819
2025	10	21	7	22	15	28.78	94.4	7.4944	72.1415
2025	10	21	7	32	15	27.94	95.8	7.4883	69.8198
2025	10	21	7	42	15	29.51	95.1	7.4883	73.8382
2025	10	21	7	52	15	27.56	96.2	7.4883	68.8152

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	21	8	2	15	27.83	95.6	7.4883	69.5687
2025	10	21	8	12	15	29.01	96.9	7.4883	72.3313
2025	10	21	8	22	15	26.9	97	7.4883	67.0572
2025	10	21	8	32	15	28.38	94.2	7.4822	71.0151
2025	10	21	8	42	15	26.98	96.6	7.4883	67.3083
2025	10	21	8	52	15	26.95	96	7.4822	67.251
2025	10	21	9	2	15	28.61	95	7.4822	71.5169
2025	10	21	9	12	15	28.44	97.5	7.4822	70.764
2025	10	21	9	22	15	28.6	94.8	7.4822	71.5168
2025	10	21	9	32	15	28.69	94.6	7.4822	71.7677
2025	10	21	9	42	15	29.04	97.3	7.4822	72.2696
2025	10	21	9	52	15	28.55	95.8	7.4822	71.2658
2025	10	21	10	2	15	27.88	96.6	7.4822	69.5092
2025	10	21	10	12	15	28.76	93.8	7.4822	72.0185
2025	10	21	10	22	15	28.39	96.7	7.4761	70.7036
2025	10	21	10	32	15	27.85	96	7.4822	69.5091
2025	10	21	10	42	15	27.81	97	7.4761	69.1992
2025	10	21	10	52	15	28.6	94.8	7.4761	71.4556
2025	10	21	11	2	15	27.17	98	7.4761	67.4441
2025	10	21	11	12	15	28.19	96.7	7.4761	70.202
2025	10	21	11	22	15	28.45	97.7	7.4761	70.7034
2025	10	21	11	32	15	28.25	95.9	7.4761	70.4526
2025	10	21	11	42	15	27.86	96.2	7.47	69.3905
2025	10	21	11	52	15	27.52	97.3	7.47	68.3885
2025	10	21	12	2	15	28.6	98.2	7.47	70.8935
2025	10	21	12	12	15	27.59	98.3	7.47	68.3885
2025	10	21	12	22	15	27.92	97.2	7.4639	69.3313
2025	10	21	12	32	15	27.51	97.1	7.4639	68.3301
2025	10	21	12	42	15	28.19	98.2	7.4639	69.8318
2025	10	21	12	52	15	27.03	97.4	7.4518	66.9641
2025	10	21	13	2	15	27.28	98.2	7.4396	67.3484
2025	10	21	13	12	15	27.66	97.9	7.4396	68.3462
2025	10	21	13	22	15	27.78	96.6	7.4335	68.7861
2025	10	21	13	32	15	27.38	96.5	7.4335	67.7892
2025	10	21	13	42	15	28.15	95.9	7.4335	69.7829
2025	10	21	13	52	15	26.72	95.4	7.4274	66.237
2025	10	21	14	2	15	26.38	96.7	7.4274	65.2409
2025	10	21	14	12	15	28.9	96.8	7.4274	71.4662
2025	10	21	14	22	15	27.75	96	7.4274	68.7271
2025	10	21	14	32	15	28.44	97.5	7.4213	70.1609
2025	10	21	14	42	15	27.86	97.8	7.4213	68.6681
2025	10	21	14	52	15	27.61	95.2	7.4213	68.4193
2025	10	21	15	2	15	27.91	97	7.4152	68.8578
2025	10	21	15	12	15	27.24	97.6	7.4152	67.1177
2025	10	21	15	22	15	26.83	95.6	7.4152	66.3719
2025	10	21	15	32	15	27.51	95.2	7.4152	68.112
2025	10	21	15	42	15	27.7	96.8	7.4091	68.3019
2025	10	21	15	52	15	27.65	97.7	7.4091	68.0535

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	21	16	2	15	26.97	96.4	7.4091	66.5633
2025	10	21	16	12	15	27.03	97.4	7.403	66.5061
2025	10	21	16	22	15	26.77	96.4	7.403	66.0098
2025	10	21	16	32	15	28.28	96.5	7.403	69.7322
2025	10	21	16	42	15	26.26	96.3	7.403	64.7691
2025	10	21	16	52	15	27.54	95.8	7.3969	67.9366
2025	10	21	17	2	15	27.7	95	7.3969	68.4325
2025	10	21	17	12	15	26.64	95.8	7.3908	65.6485
2025	10	21	17	22	15	27.56	97.9	7.3908	67.6303
2025	10	21	17	32	15	27.31	95.3	7.3908	67.3826
2025	10	21	17	42	15	28.51	95	7.3908	70.3554
2025	10	21	17	52	15	28.06	96.1	7.3847	69.0572
2025	10	21	18	2	15	28.74	97.4	7.3725	70.4205
2025	10	21	18	12	15	26.65	93.7	7.3664	65.669
2025	10	21	18	22	15	28.27	97.9	7.3603	69.0655
2025	10	21	18	32	15	27.18	96.5	7.3603	66.5989
2025	10	21	18	42	15	28.37	96.3	7.3603	69.5589
2025	10	21	18	52	15	28.21	96.9	7.3542	69.0058
2025	10	21	19	2	15	28.47	96.3	7.3542	69.7451
2025	10	21	19	12	15	28.02	98.6	7.3542	68.2664
2025	10	21	19	22	15	27.75	96	7.3542	68.02
2025	10	21	19	32	15	26.97	96.4	7.3481	65.9912
2025	10	21	19	42	15	26.91	95.1	7.3481	65.9912
2025	10	21	19	52	15	26.59	96.9	7.3481	65.0063
2025	10	21	20	2	15	27.95	96	7.3481	68.4536
2025	10	21	20	12	15	27.91	95.1	7.342	68.3943
2025	10	21	20	22	15	27.82	97.2	7.342	67.9022
2025	10	21	20	32	15	27.81	97	7.342	67.9023
2025	10	21	20	42	15	27.25	96.1	7.342	66.6722
2025	10	21	20	52	15	26.53	95.6	7.342	64.95
2025	10	21	21	2	15	26.96	96.2	7.3359	65.8769
2025	10	21	21	12	15	26.79	96.9	7.3359	65.3853
2025	10	21	21	22	15	26.65	93.7	7.3359	65.3853
2025	10	21	21	32	15	26.57	96.5	7.3359	64.8937
2025	10	21	21	42	15	28.1	98.4	7.3359	68.335
2025	10	21	21	52	15	27.51	95.2	7.3298	67.2933
2025	10	21	22	2	15	28.15	95.9	7.3298	68.7669
2025	10	21	22	12	15	26.21	97.2	7.3298	63.855
2025	10	21	22	22	15	26.56	96.3	7.3298	64.8374
2025	10	21	22	32	15	28.24	95.7	7.3237	68.9525
2025	10	21	22	42	15	27.7	94.8	7.3237	67.7256
2025	10	21	22	52	15	27.75	96	7.3237	67.7256
2025	10	21	23	2	15	27.45	97.7	7.3176	66.686
2025	10	21	23	12	15	27.5	95	7.3176	67.1763
2025	10	21	23	22	15	28.12	95.3	7.3176	68.6473
2025	10	21	23	32	15	28.65	95.8	7.3176	69.8732
2025	10	21	23	42	15	27.42	97.3	7.3115	66.6279
2025	10	21	23	52	15	27.29	96.7	7.3115	66.383

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	22	0	2	15	28.21	96.9	7.3054	68.5278
2025	10	22	0	12	15	27.3	96.9	7.2994	66.2672
2025	10	22	0	22	15	28.29	94.5	7.2933	68.8968
2025	10	22	0	32	15	27.82	97.2	7.2872	67.372
2025	10	22	0	42	15	28.44	97.5	7.2872	68.8366
2025	10	22	0	52	15	27.65	96	7.2811	67.0692
2025	10	22	1	2	15	27.21	95.1	7.2811	66.0936
2025	10	22	1	12	15	28.06	97.8	7.2811	67.8008
2025	10	22	1	22	15	25.97	94.2	7.2811	63.167
2025	10	22	1	32	15	27.07	96.4	7.2811	65.6058
2025	10	22	1	42	15	25.89	94.9	7.275	62.868
2025	10	22	1	52	15	27.76	97.9	7.275	67.0104
2025	10	22	2	2	15	25.8	97.1	7.275	62.3806
2025	10	22	2	12	15	26.94	95.8	7.275	65.3047
2025	10	22	2	22	15	26.87	98.1	7.275	64.8173
2025	10	22	2	32	15	28.53	97.2	7.2689	68.8993
2025	10	22	2	42	15	27.06	96.2	7.2689	65.4909
2025	10	22	2	52	15	27.01	97.2	7.2689	65.2474
2025	10	22	3	2	15	26.64	95.8	7.2689	64.517
2025	10	22	3	12	15	27.55	96	7.2689	66.7081
2025	10	22	3	22	15	28.03	95.5	7.2689	67.9254
2025	10	22	3	32	15	26.96	96.2	7.2689	65.2473
2025	10	22	3	42	15	26.77	98.2	7.2628	64.4603
2025	10	22	3	52	15	27.49	96.7	7.2628	66.4063
2025	10	22	4	2	15	26.92	95.3	7.2628	65.1901
2025	10	22	4	12	15	25.33	95.9	7.2628	61.2981
2025	10	22	4	22	15	26.72	95.4	7.2628	64.7035
2025	10	22	4	32	15	27.03	95.5	7.2628	65.4333
2025	10	22	4	42	15	27.45	96.1	7.2628	66.4062
2025	10	22	4	52	15	25.48	94.5	7.2567	61.7303
2025	10	22	5	2	15	27.08	96.6	7.2628	65.4332
2025	10	22	5	12	15	27.84	95.8	7.2567	67.32
2025	10	22	5	22	15	27.32	95.5	7.2567	66.1049
2025	10	22	5	32	15	27.25	96.1	7.2506	65.804
2025	10	22	5	42	15	26.7	97.1	7.2506	64.347
2025	10	22	5	52	15	27.49	96.7	7.2506	66.2896
2025	10	22	6	2	15	28.34	95.7	7.2506	68.4749
2025	10	22	6	12	15	26.19	94.8	7.2506	63.3757
2025	10	22	6	22	15	26.48	94.5	7.2445	64.0478
2025	10	22	6	32	15	26.58	94.5	7.2323	64.1773
2025	10	22	6	42	15	28.12	97.2	7.2262	67.5082
2025	10	22	6	52	15	27.27	94.2	7.2262	65.8144
2025	10	22	7	2	15	27.11	97.2	7.2262	65.0885
2025	10	22	7	12	15	29.2	96.7	7.2201	70.1078
2025	10	22	7	22	15	27.14	97.6	7.2201	65.0311
2025	10	22	7	32	15	27.41	95	7.2201	65.998
2025	10	22	7	42	15	27.55	96	7.2201	66.2398
2025	10	22	7	52	15	26.3	97	7.2201	63.097

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	22	8	2	15	27.23	98.9	7.2201	65.031
2025	10	22	8	12	15	26.53	95.6	7.2201	63.8222
2025	10	22	8	22	15	25.46	93.8	7.214	61.3505
2025	10	22	8	32	15	26.96	96.2	7.214	64.732
2025	10	22	8	42	15	26.87	96.4	7.214	64.4904
2025	10	22	8	52	15	26.35	96.1	7.214	63.2827
2025	10	22	9	2	15	27.73	95.6	7.214	66.6642
2025	10	22	9	12	15	27.71	95.2	7.214	66.6642
2025	10	22	9	22	15	27.31	95.3	7.214	65.698
2025	10	22	9	32	15	26.75	96	7.2079	64.192
2025	10	22	9	42	15	25.77	98.3	7.214	61.5919
2025	10	22	9	52	15	25.88	94.4	7.2079	62.2614
2025	10	22	10	2	15	24.02	92.1	7.2079	57.9176
2025	10	22	10	12	15	26.01	91.8	7.2079	62.744
2025	10	22	10	22	15	25.87	94.2	7.2079	62.2614
2025	10	22	10	32	15	24.93	92.8	7.2079	60.0895
2025	10	22	10	42	15	25.14	93.4	7.2079	60.5721
2025	10	22	10	52	15	24.67	94.2	7.2079	59.3655
2025	10	22	11	2	15	25.82	92.2	7.2079	62.2612
2025	10	22	11	12	15	24.22	92.6	7.2079	58.4
2025	10	22	11	22	15	25.03	93	7.2079	60.3305
2025	10	22	11	32	15	25.33	95.9	7.2079	60.8131
2025	10	22	11	42	15	25.25	93.6	7.2079	60.813
2025	10	22	11	52	15	24.71	91.9	7.2079	59.6064
2025	10	22	12	2	15	24.53	93	7.2079	59.1237
2025	10	22	12	12	15	24.73	92.8	7.2079	59.6063
2025	10	22	12	22	15	24.95	93.7	7.2018	60.0358
2025	10	22	12	32	15	25.29	94.8	7.2018	60.7591
2025	10	22	12	42	15	26.02	92.4	7.2018	62.688
2025	10	22	12	52	15	26.57	94.1	7.1957	63.837
2025	10	22	13	2	15	25.46	93.8	7.2018	61.2413
2025	10	22	13	12	15	25.63	92.9	7.1957	61.6689
2025	10	22	13	22	15	25.38	94.5	7.1957	60.9462
2025	10	22	13	32	15	26.38	94.6	7.1957	63.3551
2025	10	22	13	42	15	26.08	94.6	7.1896	62.5769
2025	10	22	13	52	15	26.45	93.7	7.1774	63.4271
2025	10	22	14	2	15	26.4	95	7.1713	63.1308
2025	10	22	14	12	15	25.84	96	7.1774	61.7454
2025	10	22	14	22	15	25.33	95.9	7.1713	60.4904
2025	10	22	14	32	15	25.45	96.3	7.1713	60.7304
2025	10	22	14	42	15	24.52	95.6	7.1652	58.518
2025	10	22	14	52	15	26.57	96.5	7.1652	63.3146
2025	10	22	15	2	15	25.28	96.8	7.1652	60.1968
2025	10	22	15	12	15	26.02	95.5	7.1591	62.0601
2025	10	22	15	22	15	27.51	95.2	7.1591	65.6543
2025	10	22	15	32	15	25.2	95	7.1591	60.1431
2025	10	22	15	42	15	27.07	94	7.1591	64.6959
2025	10	22	15	52	15	26.89	94.7	7.1591	64.2167

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	22	16	2	15	24.82	95.5	7.1591	59.1848
2025	10	22	16	12	15	25.83	95.8	7.1591	61.5809
2025	10	22	16	22	15	26.2	95	7.153	62.4837
2025	10	22	16	32	15	26.92	95.3	7.153	64.1595
2025	10	22	16	42	15	25.45	96.3	7.153	60.5685
2025	10	22	16	52	15	25.64	96	7.147	60.9929
2025	10	22	17	2	15	25.76	93.8	7.147	61.4713
2025	10	22	17	12	15	25.69	94.9	7.147	61.2321
2025	10	22	17	22	15	25.26	96.4	7.147	60.0362
2025	10	22	17	32	15	26.85	93.6	7.147	64.1024
2025	10	22	17	42	15	26.82	95.3	7.147	63.8632
2025	10	22	17	52	15	27.31	95.3	7.147	65.0592
2025	10	22	18	2	15	26.15	97.9	7.1409	61.8944
2025	10	22	18	12	15	25.69	94.9	7.1409	61.1775
2025	10	22	18	22	15	26.75	96	7.1409	63.5673
2025	10	22	18	32	15	25.13	95.9	7.1409	59.7437
2025	10	22	18	42	15	25.7	97.2	7.1409	60.9386
2025	10	22	18	52	15	26.25	96.1	7.1409	62.3724
2025	10	22	19	2	15	26.78	96.6	7.1409	63.5673
2025	10	22	19	12	15	26.52	95.4	7.1409	63.0894
2025	10	22	19	22	15	25.95	96.2	7.1409	61.6555
2025	10	22	19	32	15	27.14	97.6	7.1409	64.2842
2025	10	22	19	42	15	26.38	94.6	7.1409	62.8504
2025	10	22	19	52	15	25.97	94.2	7.1409	61.8945
2025	10	22	20	2	15	27.9	96.8	7.1409	66.1961
2025	10	22	20	12	15	25.92	95.5	7.1409	61.6556
2025	10	22	20	22	15	26	97.1	7.1409	61.6556
2025	10	22	20	32	15	26	97.1	7.1409	61.6556
2025	10	22	20	42	15	27.28	94.4	7.1348	64.9432
2025	10	22	20	52	15	26.72	95.4	7.1409	63.5674
2025	10	22	21	2	15	25.89	94.7	7.1348	61.6006
2025	10	22	21	12	15	26.82	95.3	7.1348	63.7495
2025	10	22	21	22	15	26.57	96.5	7.1348	63.0332
2025	10	22	21	32	15	27.41	95.2	7.1348	65.182
2025	10	22	21	42	15	26.23	97.7	7.1348	62.0781
2025	10	22	21	52	15	27.43	95.6	7.1348	65.1821
2025	10	22	22	2	15	26.92	95.3	7.1348	63.9883
2025	10	22	22	12	15	27.59	94.6	7.1348	65.6596
2025	10	22	22	22	15	26.47	96.5	7.1348	62.7945
2025	10	22	22	32	15	25.89	94.9	7.1348	61.6007
2025	10	22	22	42	15	26.57	94.1	7.1348	63.272
2025	10	22	22	52	15	25.32	97.5	7.1348	59.9293
2025	10	22	23	2	15	24.96	94.1	7.1287	59.3987
2025	10	22	23	12	15	26.92	95.3	7.1287	63.9311
2025	10	22	23	22	15	26.81	95.1	7.1287	63.6926
2025	10	22	23	32	15	26.42	95.4	7.1287	62.7384
2025	10	22	23	42	15	27.31	97.2	7.1287	64.6468
2025	10	22	23	52	15	26.85	93.6	7.1287	63.9311

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	23	0	2	15	26.35	96.1	7.1287	62.4998
2025	10	23	0	12	15	26.05	96.2	7.1287	61.7841
2025	10	23	0	22	15	26.36	93.9	7.1287	62.7383
2025	10	23	0	32	15	26.72	97.3	7.1287	63.2154
2025	10	23	0	42	15	27.22	95.3	7.1287	64.6467
2025	10	23	0	52	15	25.95	96.2	7.1226	61.4905
2025	10	23	1	2	15	27.41	95.2	7.1226	65.0656
2025	10	23	1	12	15	25.96	96.4	7.1226	61.4905
2025	10	23	1	22	15	25.64	96	7.1226	60.7755
2025	10	23	1	32	15	25.32	97.5	7.1226	59.8222
2025	10	23	1	42	15	26.14	95.9	7.1226	61.9672
2025	10	23	1	52	15	27.65	96	7.1226	65.5422
2025	10	23	2	2	15	26.69	96.9	7.1226	63.1589
2025	10	23	2	12	15	27.03	95.5	7.1226	64.1122
2025	10	23	2	22	15	26.68	94.3	7.1226	63.3972
2025	10	23	2	32	15	27.38	96.5	7.1226	64.8272
2025	10	23	2	42	15	26.55	96.1	7.1226	62.9205
2025	10	23	2	52	15	26.31	97.2	7.1165	62.1498
2025	10	23	3	2	15	27.64	97.5	7.1165	65.2454
2025	10	23	3	12	15	25.94	96	7.1165	61.4354
2025	10	23	3	22	15	27.49	96.7	7.1165	65.0072
2025	10	23	3	32	15	27.51	97.1	7.1165	65.0072
2025	10	23	3	42	15	27.02	95.3	7.1165	64.0547
2025	10	23	3	52	15	26.84	95.8	7.1165	63.5785
2025	10	23	4	2	15	27.31	97.2	7.1104	64.4731
2025	10	23	4	12	15	27.86	96.2	7.1104	65.9006
2025	10	23	4	22	15	25.7	97.2	7.1104	60.6666
2025	10	23	4	32	15	27.48	94.4	7.1104	65.1868
2025	10	23	4	42	15	27.76	96.2	7.1043	65.6038
2025	10	23	4	52	15	25.7	97.2	7.1104	60.6666
2025	10	23	5	2	15	25.58	96.7	7.1043	60.3745
2025	10	23	5	12	15	26.25	96.1	7.1043	62.0383
2025	10	23	5	22	15	28.11	95.1	7.0982	66.4948
2025	10	23	5	32	15	26.86	96.2	7.0921	63.3505
2025	10	23	5	42	15	26.53	95.6	7.0921	62.6387
2025	10	23	5	52	15	27.29	94.6	7.0921	64.5369
2025	10	23	6	2	15	28.54	95.6	7.0921	67.3841
2025	10	23	6	12	15	25.43	97.7	7.0921	59.7915
2025	10	23	6	22	15	25.93	95.8	7.0921	61.2151
2025	10	23	6	32	15	27.77	94.1	7.0921	65.7232
2025	10	23	6	42	15	27.48	94.4	7.0921	65.0114
2025	10	23	6	52	15	27.12	95.3	7.0921	64.0623
2025	10	23	7	2	15	26.94	95.8	7.0921	63.5878
2025	10	23	7	12	15	27.85	97.6	7.0921	65.4859
2025	10	23	7	22	15	27.38	96.5	7.086	64.4788
2025	10	23	7	32	15	27.76	96.2	7.086	65.427
2025	10	23	7	42	15	25.79	96.9	7.086	60.6859
2025	10	23	7	52	15	26.52	97.4	7.0921	62.4014

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	23	8	2	15	26.54	95.8	7.0921	62.6386
2025	10	23	8	12	15	26	95.1	7.086	61.397
2025	10	23	8	22	15	25.99	96.9	7.086	61.16
2025	10	23	8	32	15	26.7	94.9	7.086	63.0564
2025	10	23	8	42	15	26.59	94.7	7.086	62.8193
2025	10	23	8	52	15	26.29	94.8	7.086	62.1081
2025	10	23	9	2	15	26.61	95.2	7.086	62.8193
2025	10	23	9	12	15	26.48	96.7	7.086	62.3451
2025	10	23	9	22	15	25.79	94.7	7.086	60.9228
2025	10	23	9	32	15	26.89	96.8	7.086	63.2933
2025	10	23	9	42	15	25.62	95.6	7.086	60.4486
2025	10	23	9	52	15	25.58	94.5	7.086	60.4486
2025	10	23	10	2	15	26.58	96.7	7.086	62.582
2025	10	23	10	12	15	26.27	96.6	7.086	61.8708
2025	10	23	10	22	15	28.43	95.4	7.086	67.086
2025	10	23	10	32	15	26.93	97.5	7.086	63.2931
2025	10	23	10	42	15	27.6	96.9	7.086	64.9524
2025	10	23	10	52	15	27.38	94.4	7.086	64.7153
2025	10	23	11	2	15	26.4	95	7.086	62.3448
2025	10	23	11	12	15	25.46	93.8	7.086	60.2113
2025	10	23	11	22	15	25.98	94.6	7.086	61.3965
2025	10	23	11	32	15	25.79	94.9	7.086	60.9224
2025	10	23	11	42	15	24.94	96	7.086	58.7889
2025	10	23	11	52	15	24.92	92.5	7.086	59.0259
2025	10	23	12	2	15	26.6	95	7.086	62.8187
2025	10	23	12	12	15	26.76	96.2	7.086	63.0558
2025	10	23	12	22	15	27.12	95.3	7.086	64.004
2025	10	23	12	32	15	25.95	96.2	7.086	61.1593
2025	10	23	12	42	15	25.79	94.9	7.086	60.9223
2025	10	23	12	52	15	25.89	94.7	7.0799	61.1042
2025	10	23	13	2	15	25.8	95.1	7.086	60.9222
2025	10	23	13	12	15	26.15	96.1	7.086	61.6333
2025	10	23	13	22	15	26.49	94.8	7.086	62.5815
2025	10	23	13	32	15	27.44	95.9	7.0799	64.6567
2025	10	23	13	42	15	26.45	96.1	7.0799	62.2883
2025	10	23	13	52	15	25.79	96.9	7.0799	60.6304
2025	10	23	14	2	15	25.5	95	7.0799	60.1568
2025	10	23	14	12	15	26.53	95.6	7.0799	62.5251
2025	10	23	14	22	15	25.53	95.8	7.0799	60.1568
2025	10	23	14	32	15	27.17	96.3	7.0799	63.9462
2025	10	23	14	42	15	25.82	95.6	7.0799	60.8673
2025	10	23	14	52	15	26.42	97.4	7.0799	62.0515
2025	10	23	15	2	15	27.53	95.6	7.0799	64.8935
2025	10	23	15	12	15	26.63	95.6	7.0799	62.762
2025	10	23	15	22	15	28	96.8	7.0799	65.8409
2025	10	23	15	32	15	26.53	95.6	7.0799	62.5252
2025	10	23	15	42	15	26.95	96	7.0738	63.4154
2025	10	23	15	52	15	27.56	96.2	7.0738	64.8352

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	23	16	2	15	26.99	94.7	7.0738	63.6521
2025	10	23	16	12	15	26.73	95.6	7.0738	62.9422
2025	10	23	16	22	15	26.28	94.6	7.0738	61.9958
2025	10	23	16	32	15	26.24	95.9	7.0677	61.7034
2025	10	23	16	42	15	25.81	95.3	7.0677	60.7578
2025	10	23	16	52	15	26.69	94.7	7.0677	62.8855
2025	10	23	17	2	15	26.6	95	7.0677	62.6491
2025	10	23	17	12	15	26.68	94.5	7.0677	62.8855
2025	10	23	17	22	15	27.23	97.4	7.0677	63.8312
2025	10	23	17	32	15	26.58	96.7	7.0677	62.4127
2025	10	23	17	42	15	27.32	95.5	7.0677	64.304
2025	10	23	17	52	15	26.59	96.9	7.0677	62.4127
2025	10	23	18	2	15	27.08	94.4	7.0677	63.8312
2025	10	23	18	12	15	25.02	95.5	7.0616	58.8134
2025	10	23	18	22	15	26.62	95.4	7.0616	62.5926
2025	10	23	18	32	15	24.97	94.4	7.0616	58.8134
2025	10	23	18	42	15	26.62	98.9	7.0616	62.1202
2025	10	23	18	52	15	26.51	97.2	7.0616	62.1203
2025	10	23	19	2	15	25.33	95.9	7.0616	59.5221
2025	10	23	19	12	15	27.07	96.4	7.0616	63.5375
2025	10	23	19	22	15	25.54	96.1	7.0555	59.9403
2025	10	23	19	32	15	25.78	94.4	7.0616	60.7031
2025	10	23	19	42	15	26.26	98.1	7.0616	61.4117
2025	10	23	19	52	15	26.18	96.8	7.0555	61.3563
2025	10	23	20	2	15	26.06	96.4	7.0555	61.1203
2025	10	23	20	12	15	27.59	96.7	7.0555	64.6601
2025	10	23	20	22	15	26.06	96.4	7.0555	61.1203
2025	10	23	20	32	15	25.33	95.9	7.0555	59.4685
2025	10	23	20	42	15	26.42	97.4	7.0555	61.8283
2025	10	23	20	52	15	27.56	96.2	7.0555	64.6602
2025	10	23	21	2	15	27.57	99.4	7.0555	64.1882
2025	10	23	21	12	15	26.38	98.3	7.0555	61.5924
2025	10	23	21	22	15	26.18	94.6	7.0555	61.5924
2025	10	23	21	32	15	26.92	95.3	7.0494	63.1872
2025	10	23	21	42	15	25.71	100.3	7.0494	59.6506
2025	10	23	21	52	15	25.92	95.5	7.0433	60.7744
2025	10	23	22	2	15	25.89	94.7	7.0494	60.8295
2025	10	23	22	12	15	26.38	94.3	7.0494	62.0084
2025	10	23	22	22	15	25.32	97.5	7.0494	59.1791
2025	10	23	22	32	15	27.21	98.7	7.0494	63.423
2025	10	23	22	42	15	27.9	96.8	7.0433	65.2502
2025	10	23	22	52	15	25.66	93.8	7.0494	60.358
2025	10	23	23	2	15	25.93	95.8	7.0494	60.8296
2025	10	23	23	12	15	26.23	97.7	7.0433	61.2457
2025	10	23	23	22	15	26.93	97.5	7.0433	62.8946
2025	10	23	23	32	15	26.23	95.7	7.0433	61.4813
2025	10	23	23	42	15	25.79	94.9	7.0372	60.4842
2025	10	23	23	52	15	26.06	96.4	7.0372	60.9549

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	24	0	2	15	26.57	98.2	7.0311	61.8402
2025	10	24	0	12	15	26.4	95	7.0372	61.8963
2025	10	24	0	22	15	26.9	97	7.0372	62.8377
2025	10	24	0	32	15	26.66	96.2	7.0311	62.3105
2025	10	24	0	42	15	26.58	96.7	7.0311	62.0754
2025	10	24	0	52	15	26.23	95.7	7.0311	61.37
2025	10	24	1	2	15	26.57	96.5	7.0311	62.0754
2025	10	24	1	12	15	27.29	94.6	7.025	63.8984
2025	10	24	1	22	15	25.1	95	7.025	58.7302
2025	10	24	1	32	15	26.57	96.5	7.0311	62.0754
2025	10	24	1	42	15	25.59	94.9	7.025	59.9048
2025	10	24	1	52	15	27.35	96.1	7.025	63.8985
2025	10	24	2	2	15	26.7	94.9	7.025	62.4889
2025	10	24	2	12	15	26.69	96.9	7.025	62.254
2025	10	24	2	22	15	25.71	97.4	7.025	59.9048
2025	10	24	2	32	15	27.71	97	7.025	64.6032
2025	10	24	2	42	15	25.79	94.7	7.025	60.3746
2025	10	24	2	52	15	27.49	96.7	7.0189	64.0751
2025	10	24	3	2	15	26.56	96.3	7.0189	61.9628
2025	10	24	3	12	15	25.66	96.5	7.0189	59.8504
2025	10	24	3	22	15	26.47	96.5	7.0189	61.7281
2025	10	24	3	32	15	26.34	95.9	7.0189	61.4934
2025	10	24	3	42	15	26.01	95.3	7.0189	60.7892
2025	10	24	3	52	15	26.45	96.1	7.0189	61.7281
2025	10	24	4	2	15	25.98	94.6	7.0189	60.7892
2025	10	24	4	12	15	26.31	95.2	7.0189	61.4934
2025	10	24	4	22	15	27.1	97	7.0189	63.1363
2025	10	24	4	32	15	26.29	94.8	7.0189	61.4934
2025	10	24	4	42	15	26.1	97	7.0189	60.7892
2025	10	24	4	52	15	26.82	97.3	7.0189	62.4322
2025	10	24	5	2	15	25	95	7.0189	58.4422
2025	10	24	5	12	15	26.38	94.6	7.0189	61.7281
2025	10	24	5	22	15	25.69	96.9	7.0189	59.8504
2025	10	24	5	32	15	26.51	95.2	7.0189	61.9628
2025	10	24	5	42	15	26.53	95.6	7.0189	61.9628
2025	10	24	5	52	15	26.45	96.1	7.0189	61.7281
2025	10	24	6	2	15	25.66	93.8	7.0189	60.0851
2025	10	24	6	12	15	26.51	95.2	7.0189	61.9628
2025	10	24	6	22	15	26.05	97.9	7.0189	60.5545
2025	10	24	6	32	15	25.99	94.9	7.0189	60.7892
2025	10	24	6	42	15	26.45	96.1	7.0189	61.7281
2025	10	24	6	52	15	26.92	97.3	7.0189	62.6669
2025	10	24	7	2	15	26.27	96.6	7.0189	61.2587
2025	10	24	7	12	15	27.16	93.8	7.0189	63.6057
2025	10	24	7	22	15	26.53	99.1	7.0189	61.4934
2025	10	24	7	32	15	26.25	96.1	7.0189	61.2587
2025	10	24	7	42	15	27.28	96.5	7.0189	63.6057
2025	10	24	7	52	15	25.57	96.5	7.0189	59.6157

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	24	8	2	15	26.79	94.7	7.0189	62.6669
2025	10	24	8	12	15	26.67	96.5	7.0189	62.1975
2025	10	24	8	22	15	26.17	96.6	7.0189	61.024
2025	10	24	8	32	15	25.64	96	7.0189	59.8504
2025	10	24	8	42	15	26.39	98.5	7.0189	61.2586
2025	10	24	8	52	15	25.75	96.2	7.0189	60.085
2025	10	24	9	2	15	26.31	95.2	7.0189	61.4933
2025	10	24	9	12	15	25.04	93.4	7.0189	58.6767
2025	10	24	9	22	15	25.69	94.9	7.0189	60.085
2025	10	24	9	32	15	26.11	95.3	7.0189	61.0238
2025	10	24	9	42	15	26.16	96.4	7.0189	61.0237
2025	10	24	9	52	15	26.34	95.9	7.0189	61.4931
2025	10	24	10	2	15	25.84	96	7.0189	60.3195
2025	10	24	10	12	15	26.77	96.4	7.0189	62.4319
2025	10	24	10	22	15	25.49	94.7	7.0189	59.6153
2025	10	24	10	32	15	26.66	96.2	7.0189	62.1971
2025	10	24	10	42	15	25.33	95.9	7.0189	59.1459
2025	10	24	10	52	15	26.7	97.1	7.0189	62.197
2025	10	24	11	2	15	26.11	95.3	7.0189	61.0235
2025	10	24	11	12	15	27.09	96.8	7.0189	63.1358
2025	10	24	11	22	15	25.99	96.9	7.0189	60.554
2025	10	24	11	32	15	25.34	96.1	7.0189	59.1458
2025	10	24	11	42	15	26.99	94.7	7.0189	63.1357
2025	10	24	11	52	15	26.26	96.3	7.0128	61.2024
2025	10	24	12	2	15	26.04	96	7.0189	60.7886
2025	10	24	12	12	15	25.4	95.2	7.0189	59.3804
2025	10	24	12	22	15	25.48	96.8	7.0128	59.3264
2025	10	24	12	32	15	25.4	95	7.0189	59.3804
2025	10	24	12	42	15	26.54	95.8	7.0128	61.9058
2025	10	24	12	52	15	25.97	96.6	7.0128	60.4989
2025	10	24	13	2	15	27.1	94.9	7.0128	63.3127
2025	10	24	13	12	15	25.93	95.8	7.0128	60.4988
2025	10	24	13	22	15	25.37	94.3	7.0128	59.3264
2025	10	24	13	32	15	25.79	94.9	7.0128	60.2643
2025	10	24	13	42	15	26.35	93.7	7.0128	61.6713
2025	10	24	13	52	15	25.3	95.2	7.0128	59.0919
2025	10	24	14	2	15	25.74	96	7.0128	60.0298
2025	10	24	14	12	15	25.44	96.1	7.0128	59.3264
2025	10	24	14	22	15	25.22	97.5	7.0067	58.5696
2025	10	24	14	32	15	24.45	96.3	7.0128	56.9814
2025	10	24	14	42	15	25.04	96	7.0067	58.3353
2025	10	24	14	52	15	24.87	94.4	7.0067	58.101
2025	10	24	15	2	15	25.4	95	7.0067	59.2724
2025	10	24	15	12	15	25.39	97	7.0067	59.0381
2025	10	24	15	22	15	24.83	97.9	7.0067	57.6325
2025	10	24	15	32	15	25.54	93.4	7.0006	59.6866
2025	10	24	15	42	15	25.91	97.3	7.0006	60.1548
2025	10	24	15	52	15	25.46	93.8	7.0006	59.4526

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	24	16	2	15	25.39	97	7.0006	58.9845
2025	10	24	16	12	15	24	97.4	7.0006	55.7076
2025	10	24	16	22	15	25.96	98.2	7.0006	60.1549
2025	10	24	16	32	15	25.22	97.5	7.0006	58.5164
2025	10	24	16	42	15	24.99	97.1	7.0006	58.0483
2025	10	24	16	52	15	23.9	97.5	7.0006	55.4736
2025	10	24	17	2	15	26.92	97.3	7.0006	62.4955
2025	10	24	17	12	15	25.38	96.8	7.0006	58.9846
2025	10	24	17	22	15	25.71	95.4	7.0006	59.9208
2025	10	24	17	32	15	25.21	95.5	7.0006	58.7505
2025	10	24	17	42	15	25.9	97.1	7.0006	60.1549
2025	10	24	17	52	15	25.56	93.8	7.0006	59.6868
2025	10	24	18	2	15	26.72	95.4	7.0006	62.2615
2025	10	24	18	12	15	26.73	97.5	7.0006	62.0275
2025	10	24	18	22	15	26.32	97.4	7.0006	61.0912
2025	10	24	18	32	15	26.36	98.1	7.0006	61.0913
2025	10	24	18	42	15	25.94	97.8	6.9945	60.1002
2025	10	24	18	52	15	26.43	95.6	6.9945	61.5033
2025	10	24	19	2	15	25.87	96.7	6.9945	60.1002
2025	10	24	19	12	15	25.79	96.9	6.9945	59.8664
2025	10	24	19	22	15	25.96	99.5	6.9945	59.8664
2025	10	24	19	32	15	26.98	98.3	6.9945	62.4388
2025	10	24	19	42	15	25.33	97.7	6.9945	58.6972
2025	10	24	19	52	15	26.01	97.3	6.9945	60.3342
2025	10	24	20	2	15	24.46	96.6	6.9945	56.8264
2025	10	24	20	12	15	25.92	97.5	6.9945	60.1004
2025	10	24	20	22	15	25.66	93.8	6.9945	59.8666
2025	10	24	20	32	15	26.93	95.5	6.9945	62.6728
2025	10	24	20	42	15	25.26	96.4	6.9945	58.6973
2025	10	24	20	52	15	26.57	96.5	6.9945	61.7375
2025	10	24	21	2	15	25.28	96.8	6.9885	58.6438
2025	10	24	21	12	15	26.05	96.2	6.9885	60.513
2025	10	24	21	22	15	25.6	98.8	6.9885	59.1112
2025	10	24	21	32	15	26.47	94.1	6.9885	61.6813
2025	10	24	21	42	15	26.78	94.5	6.9885	62.3822
2025	10	24	21	52	15	26.45	93.7	6.9885	61.6813
2025	10	24	22	2	15	26.18	94.6	6.9885	60.9804
2025	10	24	22	12	15	25.78	96.7	6.9945	59.8668
2025	10	24	22	22	15	26.11	97.3	6.9945	60.5684
2025	10	24	22	32	15	25.94	96	6.9945	60.3346
2025	10	24	22	42	15	26.49	96.9	7.0006	61.56
2025	10	24	22	52	15	25.98	94.4	6.9945	60.5685
2025	10	24	23	2	15	26.96	96.2	6.9945	62.6732
2025	10	24	23	12	15	26.31	95.2	7.0006	61.3259
2025	10	24	23	22	15	26.43	95.6	7.0006	61.56
2025	10	24	23	32	15	26.25	96.1	7.0006	61.0919
2025	10	24	23	42	15	26.4	95	6.9945	61.504
2025	10	24	23	52	15	26.14	95.9	6.9945	60.8024

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	25	0	2	15	26.11	95.3	6.9945	60.8024
2025	10	25	0	12	15	26.12	97.5	6.9945	60.5686
2025	10	25	0	22	15	26.47	96.5	6.9945	61.504
2025	10	25	0	32	15	25.4	97.2	6.9945	58.9316
2025	10	25	0	42	15	26.55	96.1	6.9945	61.7379
2025	10	25	0	52	15	26.5	98.7	6.9945	61.2702
2025	10	25	1	2	15	25.51	95.4	6.9945	59.3993
2025	10	25	1	12	15	24.47	94.5	6.9945	57.0608
2025	10	25	1	22	15	26.03	95.7	6.9945	60.5686
2025	10	25	1	32	15	26.16	96.4	6.9945	60.8025
2025	10	25	1	42	15	25.26	96.4	6.9945	58.6978
2025	10	25	1	52	15	27.04	93	6.9885	63.0835
2025	10	25	2	2	15	26.78	94.5	6.9885	62.3825
2025	10	25	2	12	15	26.38	98.3	6.9885	60.9807
2025	10	25	2	22	15	26.14	95.9	6.9885	60.747
2025	10	25	2	32	15	26.17	96.6	6.9885	60.747
2025	10	25	2	42	15	25.39	94.7	6.9885	59.1115
2025	10	25	2	52	15	26.87	98.1	6.9885	62.1489
2025	10	25	3	2	15	25.86	96.4	6.9885	60.0461
2025	10	25	3	12	15	26.22	95.5	6.9885	60.9807
2025	10	25	3	22	15	27.58	94.4	6.9885	64.2517
2025	10	25	3	32	15	24.55	93.7	6.9885	57.2424
2025	10	25	3	42	15	26.79	94.7	6.9885	62.3825
2025	10	25	3	52	15	25.14	93.4	6.9885	58.6442
2025	10	25	4	2	15	26.48	94.5	6.9885	61.6816
2025	10	25	4	12	15	25.93	95.8	6.9885	60.2797
2025	10	25	4	22	15	25.34	96.1	6.9885	58.8779
2025	10	25	4	32	15	26.25	99.4	6.9885	60.5134
2025	10	25	4	42	15	26.23	97.7	6.9885	60.747
2025	10	25	4	52	15	26.05	96.2	6.9885	60.5134
2025	10	25	5	2	15	25.93	95.8	6.9885	60.2797
2025	10	25	5	12	15	26.52	97.4	6.9885	61.4479
2025	10	25	5	22	15	26.23	97.7	6.9885	60.747
2025	10	25	5	32	15	26.02	95.5	6.9885	60.5133
2025	10	25	5	42	15	25.73	95.8	6.9885	59.8124
2025	10	25	5	52	15	25.01	95.3	6.9885	58.1769
2025	10	25	6	2	15	26.87	98.1	6.9885	62.1488
2025	10	25	6	12	15	25.21	95.2	6.9885	58.6442
2025	10	25	6	22	15	25.58	96.7	6.9885	59.3451
2025	10	25	6	32	15	25.57	96.5	6.9885	59.3451
2025	10	25	6	42	15	26.01	97.3	6.9885	60.2797
2025	10	25	6	52	15	25.79	94.9	6.9885	60.046
2025	10	25	7	2	15	25.42	95.6	6.9885	59.1115
2025	10	25	7	12	15	26.02	95.5	6.9885	60.5133
2025	10	25	7	22	15	27.62	95.4	6.9885	64.2516
2025	10	25	7	32	15	26.31	97.2	6.9885	60.9806
2025	10	25	7	42	15	26.39	94.8	6.9885	61.4479
2025	10	25	7	52	15	26.87	98.1	6.9885	62.1488

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	25	8	2	15	26.07	96.6	6.9885	60.5133
2025	10	25	8	12	15	26.84	97.7	6.9885	62.1488
2025	10	25	8	22	15	26.42	98.9	6.9885	60.9806
2025	10	25	8	32	15	25.26	96.4	6.9885	58.6441
2025	10	25	8	42	15	27.1	97	6.9885	62.8497
2025	10	25	8	52	15	25.44	97.9	6.9885	58.8777
2025	10	25	9	2	15	26.44	95.9	6.9885	61.4478
2025	10	25	9	12	15	26.14	95.9	6.9885	60.7469
2025	10	25	9	22	15	25.45	96.3	6.9885	59.1114
2025	10	25	9	32	15	26.05	97.9	6.9885	60.2796
2025	10	25	9	42	15	25.82	95.6	6.9885	60.0459
2025	10	25	9	52	15	25.73	97.6	6.9885	59.5786
2025	10	25	10	2	15	26.57	94.1	6.9885	61.915
2025	10	25	10	12	15	26.02	95.5	6.9885	60.5132
2025	10	25	10	22	15	27.73	97.5	6.9885	64.2514
2025	10	25	10	32	15	25.9	95.1	6.9885	60.2795
2025	10	25	10	42	15	25.09	94.8	6.9885	58.4103
2025	10	25	10	52	15	26.61	97.1	6.9885	61.6813
2025	10	25	11	2	15	25.81	95.3	6.9945	60.1005
2025	10	25	11	12	15	25.95	96.2	6.9885	60.2794
2025	10	25	11	22	15	26.96	96.2	6.9945	62.6729
2025	10	25	11	32	15	26.72	97.3	6.9945	61.9713
2025	10	25	11	42	15	25.87	96.7	6.9945	60.1004
2025	10	25	11	52	15	26.2	97	6.9945	60.802
2025	10	25	12	2	15	25.42	95.6	6.9945	59.1649
2025	10	25	12	12	15	26.47	96.5	6.9945	61.5034
2025	10	25	12	22	15	25.43	97.7	6.9945	58.931
2025	10	25	12	32	15	27.24	95.9	6.9945	63.3743
2025	10	25	12	42	15	25.8	97.1	6.9945	59.8664
2025	10	25	12	52	15	25.83	95.8	6.9945	60.1002
2025	10	25	13	2	15	25.9	95.1	6.9885	60.2791
2025	10	25	13	12	15	25.83	95.8	6.9885	60.0454
2025	10	25	13	22	15	26.32	97.4	6.9824	60.9243
2025	10	25	13	32	15	25.63	95.8	6.9824	59.5237
2025	10	25	13	42	15	26.38	98.3	6.9885	60.98
2025	10	25	13	52	15	25.87	96.7	6.9824	59.9906
2025	10	25	14	2	15	25.05	98	6.9824	57.8898
2025	10	25	14	12	15	26.63	95.6	6.9824	61.858
2025	10	25	14	22	15	25.74	96	6.9763	59.7026
2025	10	25	14	32	15	25.38	96.8	6.9763	58.7697
2025	10	25	14	42	15	25.22	97.5	6.9824	58.3566
2025	10	25	14	52	15	24.84	96	6.9763	57.6037
2025	10	25	15	2	15	25.6	95.2	6.9763	59.4694
2025	10	25	15	12	15	25.43	97.7	6.9763	58.7698
2025	10	25	15	22	15	25.7	95.1	6.9824	59.7573
2025	10	25	15	32	15	25	95	6.9824	58.1233
2025	10	25	15	42	15	24.72	97.7	6.9763	57.1373
2025	10	25	15	52	15	25.14	98	6.9763	58.0702

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	25	16	2	15	25.33	95.9	6.9702	58.7161
2025	10	25	16	12	15	25.45	96.3	6.9824	59.0571
2025	10	25	16	22	15	25.24	96.1	6.9824	58.5902
2025	10	25	16	32	15	26.04	96	6.9824	60.4577
2025	10	25	16	42	15	25.83	95.8	6.9824	59.9908
2025	10	25	16	52	15	25.33	95.9	6.9824	58.8237
2025	10	25	17	2	15	24.88	96.9	6.9824	57.6565
2025	10	25	17	12	15	25.27	96.6	6.9824	58.5903
2025	10	25	17	22	15	26.55	96.1	6.9824	61.6248
2025	10	25	17	32	15	25.79	94.7	6.9763	59.936
2025	10	25	17	42	15	25.31	95.4	6.9763	58.77
2025	10	25	17	52	15	25.84	93.3	6.9763	60.1693
2025	10	25	18	2	15	25.87	96.7	6.9763	59.9361
2025	10	25	18	12	15	25.66	96.5	6.9763	59.4697
2025	10	25	18	22	15	25.59	94.9	6.9763	59.4697
2025	10	25	18	32	15	26.14	95.9	6.9763	60.6358
2025	10	25	18	42	15	25.99	94.9	6.9763	60.4025
2025	10	25	18	52	15	26.23	97.7	6.9763	60.6358
2025	10	25	19	2	15	26.96	97.9	6.9763	62.2683
2025	10	25	19	12	15	25.82	95.6	6.9763	59.9362
2025	10	25	19	22	15	24.29	97.1	6.9763	56.2048
2025	10	25	19	32	15	26.29	94.8	6.9763	61.1023
2025	10	25	19	42	15	26.5	95	6.9763	61.5687
2025	10	25	19	52	15	25.26	96.4	6.9763	58.537
2025	10	25	20	2	15	26.34	95.9	6.9763	61.1024
2025	10	25	20	12	15	25.55	96.3	6.9763	59.2367
2025	10	25	20	22	15	25.84	96	6.9763	59.9363
2025	10	25	20	32	15	26.49	96.9	6.9763	61.3357
2025	10	25	20	42	15	26.32	97.4	6.9763	60.8692
2025	10	25	20	52	15	24.83	97.9	6.9763	57.371
2025	10	25	21	2	15	27.59	94.6	6.9763	64.1343
2025	10	25	21	12	15	25.02	95.5	6.9702	58.0176
2025	10	25	21	22	15	25.23	97.7	6.9702	58.2506
2025	10	25	21	32	15	25.13	95.9	6.9702	58.2507
2025	10	25	21	42	15	26.26	98.1	6.9702	60.5807
2025	10	25	21	52	15	26.35	97.9	6.9702	60.8138
2025	10	25	22	2	15	25.45	96.3	6.9702	58.9498
2025	10	25	22	12	15	24.11	95.5	6.9702	55.9207
2025	10	25	22	22	15	25.92	97.5	6.9702	59.8818
2025	10	25	22	32	15	26.53	95.6	6.9702	61.5129
2025	10	25	22	42	15	26.05	96.2	6.9702	60.3479
2025	10	25	22	52	15	26.03	95.7	6.9702	60.3479
2025	10	25	23	2	15	24.6	97.2	6.9702	56.8529
2025	10	25	23	12	15	26.14	95.9	6.9702	60.581
2025	10	25	23	22	15	27.33	97.4	6.9702	63.144
2025	10	25	23	32	15	25.96	96.4	6.9702	60.115
2025	10	25	23	42	15	26.91	95.1	6.9702	62.445
2025	10	25	23	52	15	26.16	96.4	6.9702	60.581

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	26	0	2	15	26.39	98.5	6.9702	60.8141
2025	10	26	0	12	15	25.01	95.3	6.9702	58.018
2025	10	26	0	22	15	24.97	96.7	6.9702	57.785
2025	10	26	0	32	15	25.8	95.1	6.9702	59.8821
2025	10	26	0	42	15	25.85	96.2	6.9702	59.8821
2025	10	26	0	52	15	26.76	97.9	6.9702	61.7461
2025	10	26	1	2	15	25.58	96.7	6.9702	59.1831
2025	10	26	1	12	15	24.73	95.8	6.9641	57.2666
2025	10	26	1	22	15	25.13	95.9	6.9702	58.2511
2025	10	26	1	32	15	26.22	95.5	6.9702	60.8141
2025	10	26	1	42	15	24.96	98.3	6.9641	57.4994
2025	10	26	1	52	15	26.02	95.5	6.9641	60.2929
2025	10	26	2	2	15	25	95	6.9641	57.965
2025	10	26	2	12	15	24.15	96.4	6.9641	55.8699
2025	10	26	2	22	15	25.87	96.7	6.9641	59.8273
2025	10	26	2	32	15	26.61	95.2	6.9641	61.6897
2025	10	26	2	42	15	25.98	94.6	6.9641	60.2929
2025	10	26	2	52	15	24.6	95.1	6.9641	57.0338
2025	10	26	3	2	15	24.77	94.4	6.9641	57.4994
2025	10	26	3	12	15	25.08	96.9	6.9641	57.965
2025	10	26	3	22	15	26.05	96.2	6.9641	60.2929
2025	10	26	3	32	15	25.68	96.7	6.9641	59.3617
2025	10	26	3	42	15	25.91	97.3	6.9641	59.8273
2025	10	26	3	52	15	26.77	96.4	6.9641	61.9224
2025	10	26	4	2	15	25.54	97.9	6.9641	58.8962
2025	10	26	4	12	15	25.44	100.6	6.958	58.1445
2025	10	26	4	22	15	25.53	97.7	6.958	58.8422
2025	10	26	4	32	15	25.78	96.7	6.958	59.54
2025	10	26	4	42	15	24.41	95.4	6.958	56.5164
2025	10	26	4	52	15	26.5	95	6.9519	61.3443
2025	10	26	5	2	15	25.55	96.3	6.9519	59.0206
2025	10	26	5	12	15	26.08	94.6	6.9519	60.4148
2025	10	26	5	22	15	25.69	94.9	6.9519	59.4853
2025	10	26	5	32	15	26.38	96.7	6.9519	60.8795
2025	10	26	5	42	15	25.52	95.6	6.9458	58.9665
2025	10	26	5	52	15	25.48	96.8	6.9458	58.7343
2025	10	26	6	2	15	25.22	95.7	6.9458	58.27
2025	10	26	6	12	15	26.02	95.5	6.9458	60.1272
2025	10	26	6	22	15	25.78	96.7	6.9397	59.3762
2025	10	26	6	32	15	26.22	95.5	6.9458	60.5915
2025	10	26	6	42	15	26	95.1	6.9397	60.072
2025	10	26	6	52	15	27.05	95.9	6.9458	62.4487
2025	10	26	7	2	15	25.92	95.5	6.9397	59.8401
2025	10	26	7	12	15	26.33	95.7	6.9458	60.8237
2025	10	26	7	22	15	26.16	96.4	6.9458	60.3594
2025	10	26	7	32	15	26.22	97.5	6.9458	60.3594
2025	10	26	7	42	15	25.71	95.4	6.9397	59.3762
2025	10	26	7	52	15	25.74	97.8	6.9458	59.1986

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	26	8	2	15	24.67	96.8	6.9458	56.8771
2025	10	26	8	12	15	25.62	95.6	6.9397	59.1442
2025	10	26	8	22	15	26.37	96.5	6.9458	60.8236
2025	10	26	8	32	15	25.68	94.5	6.9397	59.3761
2025	10	26	8	42	15	26.12	95.5	6.9397	60.3038
2025	10	26	8	52	15	26.32	95.5	6.9397	60.7677
2025	10	26	9	2	15	25.62	95.6	6.9458	59.1985
2025	10	26	9	12	15	24.37	96.8	6.9458	56.1805
2025	10	26	9	22	15	25.06	96.4	6.9397	57.7525
2025	10	26	9	32	15	26.58	96.7	6.9397	61.2315
2025	10	26	9	42	15	25.88	94.4	6.9397	59.8398
2025	10	26	9	52	15	24.17	96.9	6.9397	55.6649
2025	10	26	10	2	15	25.95	98	6.9397	59.6077
2025	10	26	10	12	15	25.29	94.8	6.9397	58.448
2025	10	26	10	22	15	25.4	95	6.9458	58.7339
2025	10	26	10	32	15	25.39	94.7	6.9397	58.68
2025	10	26	10	42	15	25.47	96.5	6.9397	58.6799
2025	10	26	10	52	15	24.98	98.5	6.9397	57.2883
2025	10	26	11	2	15	24.76	96.5	6.9397	57.0563
2025	10	26	11	12	15	25.57	96.5	6.9458	58.9659
2025	10	26	11	22	15	25.33	95.9	6.9397	58.4479
2025	10	26	11	32	15	24.82	95.5	6.9397	57.2882
2025	10	26	11	42	15	25.18	96.8	6.9458	58.0373
2025	10	26	11	52	15	25.06	98.3	6.9397	57.5201
2025	10	26	12	2	15	25.4	95.2	6.9397	58.6797
2025	10	26	12	12	15	25.12	95.7	6.9397	57.9839
2025	10	26	12	22	15	25.16	96.4	6.9397	57.9839
2025	10	26	12	32	15	25.51	95.4	6.9458	58.9657
2025	10	26	12	42	15	24.8	95.1	6.9397	57.288
2025	10	26	12	52	15	25.54	96.1	6.9458	58.9657
2025	10	26	13	2	15	25.54	93.4	6.9397	59.1435
2025	10	26	13	12	15	25.17	96.6	6.9397	57.9838
2025	10	26	13	22	15	25.68	96.7	6.9397	59.1435
2025	10	26	13	32	15	24.77	94.4	6.9397	57.2881
2025	10	26	13	42	15	25.29	94.8	6.9397	58.4478
2025	10	26	13	52	15	24.79	97.2	6.9397	57.0561
2025	10	26	14	2	15	24.29	97.1	6.9397	55.8963
2025	10	26	14	12	15	24.34	96.1	6.9397	56.1282
2025	10	26	14	22	15	25.33	92.7	6.9397	58.6795
2025	10	26	14	32	15	24.63	93	6.9336	57.0035
2025	10	26	14	42	15	24.32	95.7	6.9397	56.1282
2025	10	26	14	52	15	23.78	97	6.9336	54.6863
2025	10	26	15	2	15	24.26	94	6.9275	56.025
2025	10	26	15	12	15	25.1	95	6.9336	57.9304
2025	10	26	15	22	15	25.38	96.8	6.9336	58.3939
2025	10	26	15	32	15	25.57	94.3	6.9275	59.0347
2025	10	26	15	42	15	25.89	94.7	6.9336	59.7842
2025	10	26	15	52	15	24.76	96.5	6.9275	56.9511

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	26	16	2	15	24.78	97	6.9275	56.9512
2025	10	26	16	12	15	25.38	96.8	6.9275	58.3402
2025	10	26	16	22	15	24.13	95.9	6.9275	55.5621
2025	10	26	16	32	15	25.1	95	6.9275	57.8772
2025	10	26	16	42	15	25.53	92.9	6.9275	59.0348
2025	10	26	16	52	15	24.74	96	6.9214	56.8988
2025	10	26	17	2	15	25.13	95.9	6.9214	57.824
2025	10	26	17	12	15	26.27	96.6	6.9275	60.4239
2025	10	26	17	22	15	25.54	97.9	6.9275	58.5718
2025	10	26	17	32	15	25.06	94.1	6.9275	57.8773
2025	10	26	17	42	15	25.45	96.3	6.9275	58.5718
2025	10	26	17	52	15	25.93	95.8	6.9275	59.7294
2025	10	26	18	2	15	25.48	96.8	6.9275	58.5718
2025	10	26	18	12	15	25.08	96.9	6.9275	57.6458
2025	10	26	18	22	15	25.81	97.3	6.9275	59.2664
2025	10	26	18	32	15	26.47	98.3	6.9214	60.5996
2025	10	26	18	42	15	25.52	95.6	6.9275	58.8034
2025	10	26	18	52	15	25.29	94.8	6.9275	58.3404
2025	10	26	19	2	15	25.55	96.3	6.9275	58.8034
2025	10	26	19	12	15	25.11	95.5	6.9275	57.8774
2025	10	26	19	22	15	25.26	96.4	6.9214	58.0554
2025	10	26	19	32	15	25.36	94.1	6.9214	58.518
2025	10	26	19	42	15	26.22	95.5	6.9214	60.3684
2025	10	26	19	52	15	25.63	99.2	6.9214	58.518
2025	10	26	20	2	15	26.16	96.4	6.9214	60.1371
2025	10	26	20	12	15	26.12	95.5	6.9214	60.1372
2025	10	26	20	22	15	25.22	95.7	6.9214	58.0555
2025	10	26	20	32	15	25.59	97	6.9214	58.7494
2025	10	26	20	42	15	24.98	96.9	6.9214	57.3616
2025	10	26	20	52	15	24.98	94.6	6.9214	57.593
2025	10	26	21	2	15	24.52	97.7	6.9214	56.2052
2025	10	26	21	12	15	24.82	97.6	6.9214	56.8991
2025	10	26	21	22	15	25.6	98.8	6.9214	58.5182
2025	10	26	21	32	15	25.62	95.6	6.9214	58.9808
2025	10	26	21	42	15	27.38	96.5	6.9214	62.9129
2025	10	26	21	52	15	25.5	97.2	6.9153	58.4643
2025	10	26	22	2	15	26.88	96.6	6.9153	61.6995
2025	10	26	22	12	15	26	95.1	6.9153	59.8508
2025	10	26	22	22	15	25.84	96	6.9153	59.3887
2025	10	26	22	32	15	24.53	95.9	6.9153	56.3846
2025	10	26	22	42	15	25.21	95.2	6.9153	58.0022
2025	10	26	22	52	15	26.72	97.3	6.9153	61.2374
2025	10	26	23	2	15	24.38	94.7	6.9153	56.1536
2025	10	26	23	12	15	24.21	95.5	6.9153	55.6914
2025	10	26	23	22	15	25.85	96.2	6.9153	59.3888
2025	10	26	23	32	15	24.1	97.4	6.9153	55.2293
2025	10	26	23	42	15	25.32	95.7	6.9153	58.2334
2025	10	26	23	52	15	25.52	95.6	6.9153	58.6956

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	27	0	2	15	25.89	94.9	6.9153	59.6199
2025	10	27	0	12	15	26.68	96.7	6.9153	61.2375
2025	10	27	0	22	15	25.81	97.3	6.9153	59.1578
2025	10	27	0	32	15	25.55	96.3	6.9153	58.6956
2025	10	27	0	42	15	25.71	95.4	6.9092	59.1032
2025	10	27	0	52	15	24.56	94	6.9153	56.6159
2025	10	27	1	2	15	25.82	97.6	6.9153	59.1578
2025	10	27	1	12	15	25.29	98.6	6.9153	57.7713
2025	10	27	1	22	15	25.18	94.6	6.9092	57.9489
2025	10	27	1	32	15	24.93	95.8	6.9092	57.2563
2025	10	27	1	42	15	25.4	97.2	6.9092	58.1798
2025	10	27	1	52	15	27.09	96.8	6.9092	62.1046
2025	10	27	2	2	15	25.06	96.4	6.9092	57.4872
2025	10	27	2	12	15	26.16	96.4	6.9092	60.0268
2025	10	27	2	22	15	25.43	97.7	6.9092	58.1798
2025	10	27	2	32	15	24.67	94.2	6.9092	56.7945
2025	10	27	2	42	15	25.74	97.8	6.9092	58.8724
2025	10	27	2	52	15	24.62	95.6	6.9092	56.5637
2025	10	27	3	2	15	26.11	95.3	6.9092	60.0268
2025	10	27	3	12	15	24.94	96	6.9092	57.2563
2025	10	27	3	22	15	24.43	95.9	6.9092	56.1019
2025	10	27	3	32	15	25.85	96.2	6.9092	59.3341
2025	10	27	3	42	15	25.72	95.6	6.9092	59.1033
2025	10	27	3	52	15	25.92	95.5	6.9092	59.565
2025	10	27	4	2	15	25.43	97.7	6.9092	58.1798
2025	10	27	4	12	15	25.77	98.3	6.9092	58.8724
2025	10	27	4	22	15	24.64	96.1	6.9092	56.5637
2025	10	27	4	32	15	23.93	96	6.9092	54.9476
2025	10	27	4	42	15	25.65	99.4	6.9092	58.4106
2025	10	27	4	52	15	26.16	96.4	6.9092	60.0267
2025	10	27	5	2	15	25.61	95.4	6.9092	58.8724
2025	10	27	5	12	15	25.73	95.8	6.9092	59.1033
2025	10	27	5	22	15	25.72	95.6	6.9092	59.1033
2025	10	27	5	32	15	24.88	96.9	6.9092	57.0254
2025	10	27	5	42	15	25.38	96.8	6.9092	58.1798
2025	10	27	5	52	15	25.48	96.8	6.9092	58.4106
2025	10	27	6	2	15	24.38	94.7	6.9092	56.1019
2025	10	27	6	12	15	26.79	96.9	6.9092	61.412
2025	10	27	6	22	15	25.79	96.9	6.9092	59.1032
2025	10	27	6	32	15	24.39	97.1	6.9092	55.871
2025	10	27	6	42	15	25.18	96.8	6.9092	57.718
2025	10	27	6	52	15	25.66	96.5	6.9092	58.8724
2025	10	27	7	2	15	25.74	96	6.9092	59.1032
2025	10	27	7	12	15	25.91	97.3	6.9092	59.3341
2025	10	27	7	22	15	24.88	96.9	6.9092	57.0254
2025	10	27	7	32	15	25.5	97.2	6.9092	58.4106
2025	10	27	7	42	15	24.87	96.7	6.9092	57.0254
2025	10	27	7	52	15	25.42	97.5	6.9092	58.1797

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	27	8	2	15	26.2	97	6.9092	60.0267
2025	10	27	8	12	15	24.63	92.8	6.9092	56.7945
2025	10	27	8	22	15	24.48	98.7	6.9092	55.871
2025	10	27	8	32	15	25.87	96.7	6.9092	59.3341
2025	10	27	8	42	15	25.38	96.8	6.9092	58.1797
2025	10	27	8	52	15	26.37	96.5	6.9092	60.4884
2025	10	27	9	2	15	24.98	94.6	6.9092	57.487
2025	10	27	9	12	15	25.7	97.2	6.9153	58.9266
2025	10	27	9	22	15	25.23	97.7	6.9153	57.7711
2025	10	27	9	32	15	25.09	97.1	6.9153	57.54
2025	10	27	9	42	15	26.4	98.7	6.9153	60.313
2025	10	27	9	52	15	25.47	96.5	6.9153	58.4643
2025	10	27	10	2	15	25.42	95.6	6.9153	58.4643
2025	10	27	10	12	15	25.68	96.7	6.9153	58.9264
2025	10	27	10	22	15	24.52	95.6	6.9153	56.3844
2025	10	27	10	32	15	26.22	97.5	6.9153	60.0818
2025	10	27	10	42	15	25.07	96.6	6.9153	57.5398
2025	10	27	10	52	15	25.5	95	6.9153	58.6952
2025	10	27	11	2	15	25.81	97.3	6.9153	59.1573
2025	10	27	11	12	15	25.08	96.9	6.9153	57.5397
2025	10	27	11	22	15	26.25	96.1	6.9153	60.3127
2025	10	27	11	32	15	25.43	95.9	6.9153	58.464
2025	10	27	11	42	15	24.18	94.7	6.9153	55.691
2025	10	27	11	52	15	25.02	97.6	6.9153	57.3085
2025	10	27	12	2	15	26.94	97.7	6.9153	61.6991
2025	10	27	12	12	15	25.16	94.1	6.9153	58.0017
2025	10	27	12	22	15	25.16	94.1	6.9153	58.0017
2025	10	27	12	32	15	26.66	96.2	6.9153	61.2368
2025	10	27	12	42	15	26.34	95.9	6.9153	60.5436
2025	10	27	12	52	15	25.22	99.1	6.9153	57.5395
2025	10	27	13	2	15	27.01	97.2	6.9092	61.8729
2025	10	27	13	12	15	25.75	98	6.9153	58.926
2025	10	27	13	22	15	25.71	97.4	6.9092	58.8716
2025	10	27	13	32	15	25.5	98.8	6.9092	58.179
2025	10	27	13	42	15	25.54	96.1	6.9153	58.6948
2025	10	27	13	52	15	25.6	95.2	6.9092	58.8715
2025	10	27	14	2	15	24.02	95.7	6.9092	55.1776
2025	10	27	14	12	15	24.76	98.4	6.9092	56.5628
2025	10	27	14	22	15	24.85	96.2	6.9092	57.0246
2025	10	27	14	32	15	26.53	95.6	6.9092	60.9493
2025	10	27	14	42	15	25.68	96.7	6.9092	58.8716
2025	10	27	14	52	15	25.52	95.6	6.9092	58.6407
2025	10	27	15	2	15	24.35	98.3	6.9092	55.6394
2025	10	27	15	12	15	26.57	96.5	6.9092	60.9494
2025	10	27	15	22	15	25.43	97.7	6.9031	58.1253
2025	10	27	15	32	15	25.73	97.6	6.9031	58.8172
2025	10	27	15	42	15	25.39	98.6	6.8909	57.7876
2025	10	27	15	52	15	25.09	94.8	6.8909	57.5574

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	27	16	2	15	25.4	97.2	6.8909	58.0179
2025	10	27	16	12	15	25.09	98.7	6.8909	57.097
2025	10	27	16	22	15	25.16	93.9	6.8909	57.7877
2025	10	27	16	32	15	25.64	97.8	6.8909	58.4784
2025	10	27	16	42	15	25.47	98.4	6.8848	57.9642
2025	10	27	16	52	15	25.13	95.9	6.897	57.6108
2025	10	27	17	2	15	24.74	96	6.897	56.689
2025	10	27	17	12	15	26.41	97.2	6.8909	60.3203
2025	10	27	17	22	15	26.6	98.6	6.8909	60.5505
2025	10	27	17	32	15	24.88	94.6	6.897	57.1499
2025	10	27	17	42	15	24.9	95.1	6.8909	57.0971
2025	10	27	17	52	15	25.16	98.2	6.8909	57.3273
2025	10	27	18	2	15	26.48	96.7	6.8909	60.5506
2025	10	27	18	12	15	25.9	97.1	6.8909	59.1692
2025	10	27	18	22	15	26.53	95.6	6.8909	60.7808
2025	10	27	18	32	15	24.91	97.4	6.8909	56.8669
2025	10	27	18	42	15	27.34	97.6	6.8909	62.3925
2025	10	27	18	52	15	25.87	96.7	6.8909	59.1693
2025	10	27	19	2	15	26.37	96.5	6.897	60.3763
2025	10	27	19	12	15	26.62	97.3	6.8909	60.7809
2025	10	27	19	22	15	25.28	96.8	6.8909	57.788
2025	10	27	19	32	15	25.89	94.7	6.897	59.4546
2025	10	27	19	42	15	24.64	96.1	6.897	56.4589
2025	10	27	19	52	15	25.04	96	6.897	57.3807
2025	10	27	20	2	15	26.57	96.5	6.8909	60.7811
2025	10	27	20	12	15	25.78	96.7	6.8909	58.9393
2025	10	27	20	22	15	25.08	96.9	6.8909	57.3277
2025	10	27	20	32	15	25.51	97.4	6.8909	58.2486
2025	10	27	20	42	15	25.53	97.7	6.8909	58.2486
2025	10	27	20	52	15	25.18	96.8	6.897	57.6113
2025	10	27	21	2	15	26.37	96.5	6.897	60.3766
2025	10	27	21	12	15	24.64	96.1	6.8909	56.4069
2025	10	27	21	22	15	26.76	96.2	6.8909	61.2418
2025	10	27	21	32	15	25.73	99.2	6.8909	58.479
2025	10	27	21	42	15	25.52	95.6	6.8909	58.479
2025	10	27	21	52	15	25.48	98.6	6.8909	58.0186
2025	10	27	22	2	15	24.83	95.8	6.8909	56.8675
2025	10	27	22	12	15	24.67	96.8	6.8909	56.407
2025	10	27	22	22	15	25.06	96.4	6.8909	57.328
2025	10	27	22	32	15	25.33	95.9	6.8909	58.0187
2025	10	27	22	42	15	25.29	97	6.8909	57.7885
2025	10	27	22	52	15	25.23	95.9	6.8909	57.7885
2025	10	27	23	2	15	25.26	96.4	6.8848	57.735
2025	10	27	23	12	15	25.18	94.6	6.8909	57.7885
2025	10	27	23	22	15	24.8	95.1	6.8909	56.8676
2025	10	27	23	32	15	26.17	94.2	6.8909	60.0909
2025	10	27	23	42	15	25.97	96.6	6.8909	59.4002
2025	10	27	23	52	15	25.86	93.8	6.8909	59.4002

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	28	0	2	15	25.52	95.6	6.8909	58.4793
2025	10	28	0	12	15	26.07	96.6	6.8909	59.6305
2025	10	28	0	22	15	25.17	96.6	6.8909	57.5584
2025	10	28	0	32	15	25.63	95.8	6.8909	58.7096
2025	10	28	0	42	15	23.94	96.2	6.8909	54.7956
2025	10	28	0	52	15	25.42	95.6	6.8909	58.2491
2025	10	28	1	2	15	25.38	96.8	6.8909	58.0189
2025	10	28	1	12	15	24.48	97	6.8909	55.9468
2025	10	28	1	22	15	25.19	94.8	6.8909	57.7887
2025	10	28	1	32	15	25.54	97.9	6.8909	58.2492
2025	10	28	1	42	15	26.47	98.3	6.8909	60.3213
2025	10	28	1	52	15	25.32	95.7	6.8909	58.019
2025	10	28	2	2	15	24.65	96.3	6.8909	56.4073
2025	10	28	2	12	15	25.48	94.5	6.8909	58.4794
2025	10	28	2	22	15	25.2	95	6.8909	57.7887
2025	10	28	2	32	15	25.36	100.9	6.8909	57.3283
2025	10	28	2	42	15	25.82	97.6	6.8909	58.9399
2025	10	28	2	52	15	24.7	95.1	6.8909	56.6376
2025	10	28	3	2	15	24.98	96.9	6.8909	57.0981
2025	10	28	3	12	15	26.86	96.2	6.8909	61.4725
2025	10	28	3	22	15	24.75	96.3	6.8909	56.6376
2025	10	28	3	32	15	25.15	96.2	6.8909	57.5585
2025	10	28	3	42	15	25.11	95.3	6.8909	57.5585
2025	10	28	3	52	15	25.7	97.2	6.8909	58.7097
2025	10	28	4	2	15	25.1	95	6.8909	57.5585
2025	10	28	4	12	15	24.56	96.5	6.8909	56.1771
2025	10	28	4	22	15	25.69	96.9	6.8909	58.7097
2025	10	28	4	32	15	25.55	96.3	6.8909	58.4795
2025	10	28	4	42	15	26.3	97	6.8909	60.0911
2025	10	28	4	52	15	24.86	96.5	6.8909	56.8678
2025	10	28	5	2	15	25.69	96.9	6.8909	58.7097
2025	10	28	5	12	15	25.23	97.7	6.8909	57.5585
2025	10	28	5	22	15	25.58	94.5	6.8909	58.7097
2025	10	28	5	32	15	25.32	95.7	6.8909	58.019
2025	10	28	5	42	15	24.86	98.3	6.8909	56.6376
2025	10	28	5	52	15	25.58	96.7	6.8909	58.4794
2025	10	28	6	2	15	25.48	94.5	6.8909	58.4794
2025	10	28	6	12	15	24.73	95.8	6.8909	56.6376
2025	10	28	6	22	15	25.2	97.3	6.8909	57.5585
2025	10	28	6	32	15	24.71	97.4	6.8909	56.4073
2025	10	28	6	42	15	25.72	95.6	6.8909	58.9399
2025	10	28	6	52	15	25.53	99.2	6.8909	58.019
2025	10	28	7	2	15	27.21	97.2	6.8909	62.1632
2025	10	28	7	12	15	24.96	93.9	6.897	57.3813
2025	10	28	7	22	15	25.58	96.7	6.897	58.5336
2025	10	28	7	32	15	26.12	95.5	6.8909	59.8608
2025	10	28	7	42	15	26.02	95.5	6.897	59.6858
2025	10	28	7	52	15	26.57	96.5	6.897	60.8381

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	28	8	2	15	27.07	96.4	6.897	61.9903
2025	10	28	8	12	15	25.23	95.9	6.897	57.8422
2025	10	28	8	22	15	24.83	97.9	6.897	56.69
2025	10	28	8	32	15	26.08	94.6	6.897	59.9162
2025	10	28	8	42	15	24.81	95.3	6.897	56.9204
2025	10	28	8	52	15	25.98	94.4	6.897	59.6857
2025	10	28	9	2	15	25.58	96.7	6.897	58.5334
2025	10	28	9	12	15	25.13	95.9	6.897	57.6116
2025	10	28	9	22	15	25.64	96	6.897	58.7638
2025	10	28	9	32	15	25.7	97.2	6.897	58.7638
2025	10	28	9	42	15	24.64	97.9	6.897	56.2288
2025	10	28	9	52	15	27.09	99.8	6.897	61.5291
2025	10	28	10	2	15	24.91	97.4	6.897	56.9201
2025	10	28	10	12	15	25.18	96.8	6.897	57.6114
2025	10	28	10	22	15	25.12	97.5	6.9031	57.434
2025	10	28	10	32	15	24.73	97.9	6.9031	56.5114
2025	10	28	10	42	15	25.78	96.7	6.9031	59.0486
2025	10	28	10	52	15	25.23	95.9	6.897	57.8418
2025	10	28	11	2	15	26.08	98.4	6.9031	59.5098
2025	10	28	11	12	15	24.82	95.5	6.9031	56.9726
2025	10	28	11	22	15	25.12	97.5	6.9031	57.4339
2025	10	28	11	32	15	25.68	96.7	6.9031	58.8178
2025	10	28	11	42	15	25.47	96.5	6.9031	58.3565
2025	10	28	11	52	15	24.78	97	6.9031	56.7418
2025	10	28	12	2	15	25.7	97.2	6.9031	58.8177
2025	10	28	12	12	15	25.1	95	6.9031	57.6644
2025	10	28	12	22	15	24.78	97	6.9031	56.7418
2025	10	28	12	32	15	25.5	95.2	6.9031	58.587
2025	10	28	12	42	15	25	95	6.9031	57.4337
2025	10	28	12	52	15	25.44	96.1	6.9031	58.3563
2025	10	28	13	2	15	25.04	96	6.9031	57.4336
2025	10	28	13	12	15	24.17	96.9	6.897	55.3065
2025	10	28	13	22	15	24.44	98	6.897	55.7674
2025	10	28	13	32	15	24.66	96.5	6.897	56.4587
2025	10	28	13	42	15	26.97	96.4	6.897	61.759
2025	10	28	13	52	15	26.41	95.2	6.897	60.6068
2025	10	28	14	2	15	25.49	97	6.897	58.3023
2025	10	28	14	12	15	26.34	99.2	6.897	59.9154
2025	10	28	14	22	15	25.95	96.2	6.8909	59.3995
2025	10	28	14	32	15	24.64	97.9	6.8848	56.1243
2025	10	28	14	42	15	25.51	97.4	6.8848	58.1945
2025	10	28	14	52	15	25.85	96.2	6.8848	59.1146
2025	10	28	15	2	15	25.6	98.8	6.8848	58.1945
2025	10	28	15	12	15	26.46	98	6.8787	60.2088
2025	10	28	15	22	15	25.03	97.8	6.8787	56.9916
2025	10	28	15	32	15	24.67	96.8	6.8726	56.2499
2025	10	28	15	42	15	25.18	96.8	6.8726	57.3979
2025	10	28	15	52	15	25.06	96.4	6.8787	57.2215

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	28	16	2	15	25.63	97.6	6.8787	58.3705
2025	10	28	16	12	15	25.63	97.6	6.8726	58.3164
2025	10	28	16	22	15	25.26	96.4	6.8726	57.6276
2025	10	28	16	32	15	25.16	93.9	6.8787	57.6812
2025	10	28	16	42	15	26.17	96.6	6.8787	59.7494
2025	10	28	16	52	15	26.61	95.2	6.8726	60.842
2025	10	28	17	2	15	25.08	96.9	6.8726	57.1685
2025	10	28	17	12	15	25.23	95.9	6.8726	57.6277
2025	10	28	17	22	15	23.91	95.5	6.8726	54.643
2025	10	28	17	32	15	25.56	93.8	6.8726	58.5461
2025	10	28	17	42	15	24.95	98.1	6.8726	56.7094
2025	10	28	17	52	15	25.66	96.5	6.8726	58.5461
2025	10	28	18	2	15	24.24	96.2	6.8726	55.3318
2025	10	28	18	12	15	26.42	95.4	6.8726	60.3829
2025	10	28	18	22	15	25.39	97	6.8726	57.8574
2025	10	28	18	32	15	24.96	93.9	6.8665	57.1155
2025	10	28	18	42	15	25.74	96	6.8726	58.7758
2025	10	28	18	52	15	25.76	96.5	6.8726	58.7758
2025	10	28	19	2	15	25.72	95.6	6.8726	58.7758
2025	10	28	19	12	15	25.41	95.4	6.8665	58.0331
2025	10	28	19	22	15	24.88	96.9	6.8726	56.7095
2025	10	28	19	32	15	25.95	98	6.8726	59.0055
2025	10	28	19	42	15	26.18	96.8	6.8726	59.6943
2025	10	28	19	52	15	24.48	97	6.8726	55.7912
2025	10	28	20	2	15	23.85	96.5	6.8726	54.4137
2025	10	28	20	12	15	24.2	95.2	6.8787	55.3835
2025	10	28	20	22	15	25.32	97.5	6.8726	57.6281
2025	10	28	20	32	15	25.05	98	6.8726	56.9393
2025	10	28	20	42	15	25.65	96.3	6.8787	58.6009
2025	10	28	20	52	15	25.74	97.8	6.8787	58.6009
2025	10	28	21	2	15	25.23	95.9	6.8787	57.6817
2025	10	28	21	12	15	24.92	97.6	6.8787	56.7625
2025	10	28	21	22	15	25.87	94.2	6.8787	59.2904
2025	10	28	21	32	15	26.24	95.9	6.8848	60.0355
2025	10	28	21	42	15	23.48	97.1	6.8848	53.5949
2025	10	28	21	52	15	26.39	94.8	6.8848	60.4956
2025	10	28	22	2	15	25.99	96.9	6.8787	59.2905
2025	10	28	22	12	15	25.69	96.9	6.8848	58.6555
2025	10	28	22	22	15	25.13	95.9	6.8787	57.4521
2025	10	28	22	32	15	25.15	96.2	6.8848	57.5054
2025	10	28	22	42	15	23.82	97.7	6.8787	54.2348
2025	10	28	22	52	15	24.88	96.9	6.8787	56.7627
2025	10	28	23	2	15	25.58	96.7	6.8787	58.3714
2025	10	28	23	12	15	25.89	96.9	6.8787	59.0609
2025	10	28	23	22	15	26.38	96.7	6.8787	60.2099
2025	10	28	23	32	15	25.09	94.8	6.8787	57.4522
2025	10	28	23	42	15	25.04	96	6.8787	57.2224
2025	10	28	23	52	15	26.33	97.6	6.8787	59.9802

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	29	0	2	15	26.46	98	6.8787	60.21
2025	10	29	0	12	15	25.54	96.1	6.8787	58.3715
2025	10	29	0	22	15	25.62	95.6	6.8787	58.6014
2025	10	29	0	32	15	24.61	95.4	6.8787	56.3033
2025	10	29	0	42	15	26.45	96.1	6.8787	60.4399
2025	10	29	0	52	15	25.3	95.2	6.8787	57.912
2025	10	29	1	2	15	25.65	96.3	6.8787	58.6014
2025	10	29	1	12	15	24.31	95.4	6.8726	55.5623
2025	10	29	1	22	15	25.92	97.5	6.8787	59.061
2025	10	29	1	32	15	25.69	94.9	6.8726	58.7767
2025	10	29	1	42	15	25.02	95.5	6.8726	57.1695
2025	10	29	1	52	15	25.05	96.2	6.8726	57.1695
2025	10	29	2	2	15	25.58	96.7	6.8726	58.3175
2025	10	29	2	12	15	25.48	96.8	6.8726	58.0879
2025	10	29	2	22	15	24.68	97	6.8726	56.2511
2025	10	29	2	32	15	25.49	97	6.8665	58.034
2025	10	29	2	42	15	25.12	95.7	6.8665	57.3458
2025	10	29	2	52	15	26.21	97.2	6.8604	59.5842
2025	10	29	3	2	15	25.29	98.6	6.8604	57.2925
2025	10	29	3	12	15	24.57	96.8	6.8604	55.9175
2025	10	29	3	22	15	25	95	6.8604	57.0634
2025	10	29	3	32	15	23.84	93.4	6.8543	54.4918
2025	10	29	3	42	15	26.36	93.9	6.8543	60.2157
2025	10	29	3	52	15	25.02	92.3	6.8543	57.2392
2025	10	29	4	2	15	24.42	97.8	6.8543	55.4076
2025	10	29	4	12	15	25.09	94.8	6.8482	57.186
2025	10	29	4	22	15	25.34	97.9	6.8482	57.4147
2025	10	29	4	32	15	25.48	96.8	6.8482	57.8722
2025	10	29	4	42	15	24.4	97.3	6.8482	55.356
2025	10	29	4	52	15	25.9	97.1	6.8482	58.7872
2025	10	29	5	2	15	25.42	95.6	6.8482	57.8722
2025	10	29	5	12	15	24.92	97.6	6.8482	56.4997
2025	10	29	5	22	15	24.17	94.5	6.8482	55.1273
2025	10	29	5	32	15	25.94	97.8	6.8482	58.7872
2025	10	29	5	42	15	22.95	93.7	6.8482	52.3823
2025	10	29	5	52	15	23.4	95.4	6.8482	53.2973
2025	10	29	6	2	15	25.12	95.7	6.8482	57.186
2025	10	29	6	12	15	25.44	96.1	6.8482	57.8722
2025	10	29	6	22	15	25.62	95.6	6.8482	58.3297
2025	10	29	6	32	15	25.12	95.7	6.8482	57.186
2025	10	29	6	42	15	25.88	94.4	6.8482	59.0159
2025	10	29	6	52	15	24.65	98.2	6.8482	55.8135
2025	10	29	7	2	15	24.42	95.6	6.8482	55.5847
2025	10	29	7	12	15	24.98	96.9	6.8421	56.6756
2025	10	29	7	22	15	25.86	96.4	6.8421	58.7324
2025	10	29	7	32	15	25.21	95.5	6.8421	57.3612
2025	10	29	7	42	15	25.42	95.6	6.8421	57.8183
2025	10	29	7	52	15	25.68	96.7	6.8421	58.2753

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	29	8	2	15	26.45	96.1	6.8421	60.1036
2025	10	29	8	12	15	24.59	94.9	6.8421	55.99
2025	10	29	8	22	15	25.04	96	6.8421	56.9041
2025	10	29	8	32	15	25.8	97.1	6.8421	58.5038
2025	10	29	8	42	15	26.43	95.6	6.8421	60.1035
2025	10	29	8	52	15	25.26	98.2	6.8421	57.1326
2025	10	29	9	2	15	25.09	98.7	6.8421	56.6755
2025	10	29	9	12	15	25.79	94.7	6.8421	58.7322
2025	10	29	9	22	15	25.06	96.4	6.8421	56.9039
2025	10	29	9	32	15	25.24	96.1	6.8421	57.361
2025	10	29	9	42	15	25.08	96.9	6.8482	56.9569
2025	10	29	9	52	15	25.58	96.7	6.8482	58.1006
2025	10	29	10	2	15	24.69	94.9	6.8482	56.2706
2025	10	29	10	12	15	25.1	95	6.8482	57.1856
2025	10	29	10	22	15	25.26	98.2	6.8482	57.1855
2025	10	29	10	32	15	25.87	96.7	6.8482	58.7867
2025	10	29	10	42	15	25.61	97.4	6.8482	58.1004
2025	10	29	10	52	15	25.46	98.1	6.8482	57.6429
2025	10	29	11	2	15	24.42	95.6	6.8482	55.5842
2025	10	29	11	12	15	24.39	97.1	6.8482	55.3554
2025	10	29	11	22	15	24.29	95	6.8482	55.3554
2025	10	29	11	32	15	24.68	97	6.8482	56.0416
2025	10	29	11	42	15	24.57	94.4	6.8482	56.0416
2025	10	29	11	52	15	25	95	6.8482	56.9565
2025	10	29	12	2	15	24.92	95.5	6.8482	56.7277
2025	10	29	12	12	15	24.06	94.1	6.8482	54.8978
2025	10	29	12	22	15	24.8	95.1	6.8482	56.499
2025	10	29	12	32	15	24.51	97.5	6.8482	55.584
2025	10	29	12	42	15	24.87	96.7	6.8482	56.4989
2025	10	29	12	52	15	26.17	96.6	6.8482	59.4725
2025	10	29	13	2	15	24.82	95.5	6.8482	56.4989
2025	10	29	13	12	15	25.42	97.5	6.8482	57.6426
2025	10	29	13	22	15	26.57	96.5	6.8482	60.3875
2025	10	29	13	32	15	25.73	99.2	6.8482	58.1001
2025	10	29	13	42	15	24.35	96.4	6.8482	55.3552
2025	10	29	13	52	15	25.13	95.9	6.8482	57.1851
2025	10	29	14	2	15	24.09	97.2	6.8482	54.669
2025	10	29	14	12	15	25.72	95.6	6.8482	58.5576
2025	10	29	14	22	15	24.56	96.5	6.8482	55.8127
2025	10	29	14	32	15	23.94	96.2	6.8482	54.4402
2025	10	29	14	42	15	25.09	97.1	6.8482	56.9564
2025	10	29	14	52	15	26.02	97.5	6.8482	59.0151
2025	10	29	15	2	15	24.5	95.2	6.8482	55.8127
2025	10	29	15	12	15	24.17	96.9	6.8482	54.8978
2025	10	29	15	22	15	23.79	95.1	6.8482	54.2116
2025	10	29	15	32	15	24.15	93.6	6.8482	55.1265
2025	10	29	15	42	15	24.85	96.2	6.8482	56.4991
2025	10	29	15	52	15	26.25	97.9	6.8421	59.4173

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	29	16	2	15	25.68	96.7	6.8482	58.329
2025	10	29	16	12	15	25.66	96.5	6.8421	58.2747
2025	10	29	16	22	15	24.37	96.8	6.8421	55.3038
2025	10	29	16	32	15	25.18	94.6	6.8421	57.3606
2025	10	29	16	42	15	24.53	95.9	6.8482	55.8129
2025	10	29	16	52	15	26.47	96.5	6.8421	60.103
2025	10	29	17	2	15	25.78	96.7	6.8421	58.5033
2025	10	29	17	12	15	24.47	96.8	6.8421	55.5324
2025	10	29	17	22	15	26.42	97.4	6.8421	59.8745
2025	10	29	17	32	15	25.53	95.8	6.8421	58.0462
2025	10	29	17	42	15	24.35	98.3	6.8421	55.0754
2025	10	29	17	52	15	24.42	95.6	6.8421	55.5325
2025	10	29	18	2	15	25.53	97.7	6.8421	57.8177
2025	10	29	18	12	15	25.15	96.2	6.8421	57.1322
2025	10	29	18	22	15	25.54	96.1	6.8421	58.0463
2025	10	29	18	32	15	26.42	95.4	6.8421	60.1031
2025	10	29	18	42	15	26.21	97.2	6.8421	59.4175
2025	10	29	18	52	15	25.54	96.1	6.8421	58.0464
2025	10	29	19	2	15	25.54	96.1	6.8421	58.0464
2025	10	29	19	12	15	25.03	95.7	6.8421	56.9038
2025	10	29	19	22	15	25.41	95.4	6.8421	57.8179
2025	10	29	19	32	15	24.84	96	6.8421	56.4468
2025	10	29	19	42	15	25.22	97.5	6.8421	57.1324
2025	10	29	19	52	15	25.89	94.7	6.8421	58.9606
2025	10	29	20	2	15	24.49	94.9	6.8421	55.7612
2025	10	29	20	12	15	25.2	98.9	6.8421	56.9039
2025	10	29	20	22	15	25.93	95.8	6.8421	58.9607
2025	10	29	20	32	15	25.78	96.7	6.8421	58.5037
2025	10	29	20	42	15	23.59	97.3	6.8421	53.476
2025	10	29	20	52	15	23.66	94.1	6.8421	53.9331
2025	10	29	21	2	15	24.78	97	6.8421	56.2184
2025	10	29	21	12	15	25.09	94.8	6.8421	57.1326
2025	10	29	21	22	15	24.67	96.8	6.8421	55.99
2025	10	29	21	32	15	25.02	97.6	6.8421	56.6756
2025	10	29	21	42	15	23.86	98.4	6.8421	53.9332
2025	10	29	21	52	15	24.58	97	6.8421	55.7615
2025	10	29	22	2	15	25.54	96.1	6.8421	58.0468
2025	10	29	22	12	15	24.17	94.5	6.8421	55.076
2025	10	29	22	22	15	24.98	96.9	6.8421	56.6757
2025	10	29	22	32	15	24.59	94.9	6.8421	55.9901
2025	10	29	22	42	15	26.47	96.5	6.8421	60.1037
2025	10	29	22	52	15	24.94	96	6.8421	56.6758
2025	10	29	23	2	15	24.58	97	6.8482	55.8137
2025	10	29	23	12	15	24.88	96.9	6.8421	56.4473
2025	10	29	23	22	15	25.86	94	6.8421	58.9611
2025	10	29	23	32	15	24.02	95.7	6.8482	54.67
2025	10	29	23	42	15	24.84	96	6.8421	56.4473
2025	10	29	23	52	15	24.87	94.2	6.8421	56.6759

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	30	0	2	15	26.17	96.6	6.8421	59.4183
2025	10	30	0	12	15	24.14	96.2	6.8421	54.8476
2025	10	30	0	22	15	24.73	97.9	6.8421	55.9903
2025	10	30	0	32	15	26.13	95.7	6.8421	59.4183
2025	10	30	0	42	15	25.45	96.3	6.8421	57.8186
2025	10	30	0	52	15	24.72	97.7	6.8482	56.0426
2025	10	30	1	2	15	26.54	95.8	6.8421	60.3325
2025	10	30	1	12	15	24.95	98.1	6.8421	56.4474
2025	10	30	1	22	15	25.32	97.5	6.8421	57.3616
2025	10	30	1	32	15	25.78	96.7	6.8482	58.5588
2025	10	30	1	42	15	25.67	98.3	6.8421	58.0472
2025	10	30	1	52	15	26.02	95.5	6.8421	59.1898
2025	10	30	2	2	15	24.81	95.3	6.8421	56.4475
2025	10	30	2	12	15	25.6	97.2	6.8421	58.0472
2025	10	30	2	22	15	25.16	93.9	6.8482	57.4151
2025	10	30	2	32	15	24.67	96.8	6.8421	55.9904
2025	10	30	2	42	15	25.86	96.4	6.8421	58.7328
2025	10	30	2	52	15	24.01	97.7	6.8421	54.3907
2025	10	30	3	2	15	25.39	98.6	6.8421	57.3616
2025	10	30	3	12	15	24.47	94.5	6.8482	55.8139
2025	10	30	3	22	15	25.23	95.9	6.8421	57.3616
2025	10	30	3	32	15	24.69	94.9	6.8482	56.2714
2025	10	30	3	42	15	25.1	97.3	6.8482	56.9576
2025	10	30	3	52	15	25.47	98.4	6.8482	57.6438
2025	10	30	4	2	15	24.52	95.6	6.8482	55.8139
2025	10	30	4	12	15	25.71	97.4	6.8482	58.3301
2025	10	30	4	22	15	25.17	96.6	6.8482	57.1863
2025	10	30	4	32	15	25.63	97.6	6.8482	58.1013
2025	10	30	4	42	15	25.99	96.9	6.8543	59.0713
2025	10	30	4	52	15	25.52	99	6.8482	57.6438
2025	10	30	5	2	15	24.7	97.2	6.8482	56.0426
2025	10	30	5	12	15	24.58	97	6.8543	55.8659
2025	10	30	5	22	15	23.98	96.9	6.8482	54.4414
2025	10	30	5	32	15	25.03	97.8	6.8482	56.7288
2025	10	30	5	42	15	24.41	95.4	6.8482	55.5851
2025	10	30	5	52	15	25.27	96.6	6.8543	57.4686
2025	10	30	6	2	15	24.55	98.2	6.8482	55.5851
2025	10	30	6	12	15	25.63	95.8	6.8543	58.3844
2025	10	30	6	22	15	25.51	97.4	6.8543	57.9265
2025	10	30	6	32	15	23.69	97.3	6.8543	53.8052
2025	10	30	6	42	15	26.29	98.5	6.8543	59.5292
2025	10	30	6	52	15	24.42	95.6	6.8543	55.6369
2025	10	30	7	2	15	25.81	95.3	6.8604	58.8971
2025	10	30	7	12	15	25.62	95.6	6.8543	58.3844
2025	10	30	7	22	15	25.79	96.9	6.8543	58.6133
2025	10	30	7	32	15	25.45	99.5	6.8543	57.4685
2025	10	30	7	42	15	25.05	96.2	6.8543	57.0106
2025	10	30	7	52	15	26.13	95.7	6.8604	59.5846

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	30	8	2	15	24.09	97.2	6.8543	54.721
2025	10	30	8	12	15	25.08	96.9	6.8665	57.1167
2025	10	30	8	22	15	26.67	96.5	6.8604	60.7304
2025	10	30	8	32	15	22.86	94.3	6.8604	52.251
2025	10	30	8	42	15	24.94	96	6.8665	56.8873
2025	10	30	8	52	15	25.47	94.3	6.8604	58.2094
2025	10	30	9	2	15	25.19	97.1	6.8543	57.2394
2025	10	30	9	12	15	26.32	95.5	6.8604	60.0427
2025	10	30	9	22	15	25.97	96.6	6.8604	59.126
2025	10	30	9	32	15	25.48	96.8	6.8543	57.9262
2025	10	30	9	42	15	25.87	96.7	6.8604	58.8967
2025	10	30	9	52	15	24.89	97.2	6.8604	56.605
2025	10	30	10	2	15	23.72	95.8	6.8604	54.0841
2025	10	30	10	12	15	25.72	95.6	6.8604	58.6675
2025	10	30	10	22	15	25.36	96.3	6.8604	57.7507
2025	10	30	10	32	15	26.28	98.3	6.8665	59.6395
2025	10	30	10	42	15	25.29	94.8	6.8726	57.8581
2025	10	30	10	52	15	26.16	98.1	6.8726	59.4652
2025	10	30	11	2	15	25.64	97.8	6.8665	58.2631
2025	10	30	11	12	15	23.99	97.2	6.8665	54.5929
2025	10	30	11	22	15	25.65	96.3	6.8726	58.5467
2025	10	30	11	32	15	25.3	97.3	6.8726	57.6283
2025	10	30	11	42	15	25.53	95.8	6.8665	58.263
2025	10	30	11	52	15	25.68	96.7	6.8665	58.4923
2025	10	30	12	2	15	25.8	97.1	6.8726	58.7763
2025	10	30	12	12	15	25.05	98	6.8665	56.8866
2025	10	30	12	22	15	25.61	97.4	6.8665	58.2629
2025	10	30	12	32	15	25.36	96.3	6.8726	57.8578
2025	10	30	12	42	15	24.31	99.2	6.8665	55.0515
2025	10	30	12	52	15	26.21	98.8	6.8665	59.4097
2025	10	30	13	2	15	25.44	93.4	6.8665	58.2628
2025	10	30	13	12	15	24.32	95.7	6.8665	55.5102
2025	10	30	13	22	15	25.74	97.8	6.8665	58.4922
2025	10	30	13	32	15	24.89	97.2	6.8665	56.6571
2025	10	30	13	42	15	25.78	96.7	6.8604	58.667
2025	10	30	13	52	15	25.58	98.5	6.8665	58.0334
2025	10	30	14	2	15	26.02	97.5	6.8604	59.1253
2025	10	30	14	12	15	24.45	96.3	6.8604	55.6878
2025	10	30	14	22	15	25.65	96.3	6.8604	58.4378
2025	10	30	14	32	15	23.5	95.4	6.8665	53.6751
2025	10	30	14	42	15	24.7	95.1	6.8604	56.3753
2025	10	30	14	52	15	23.1	97.5	6.8604	52.4794
2025	10	30	15	2	15	24.79	97.2	6.8665	56.4277
2025	10	30	15	12	15	24.27	94.3	6.8604	55.4586
2025	10	30	15	22	15	24.71	95.3	6.8604	56.3753
2025	10	30	15	32	15	25.09	94.8	6.8604	57.292
2025	10	30	15	42	15	25.1	95	6.8604	57.2921
2025	10	30	15	52	15	24.47	96.8	6.8604	55.6879

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	30	16	2	15	25.34	97.9	6.8604	57.5213
2025	10	30	16	12	15	25.13	95.9	6.8543	57.2388
2025	10	30	16	22	15	25.07	98.5	6.8543	56.7809
2025	10	30	16	32	15	24.9	95.1	6.8543	56.7809
2025	10	30	16	42	15	25.6	97.2	6.8543	58.1547
2025	10	30	16	52	15	25.63	97.6	6.8543	58.1547
2025	10	30	17	2	15	25.91	97.3	6.8543	58.8416
2025	10	30	17	12	15	24.36	96.6	6.8543	55.4072
2025	10	30	17	22	15	25.11	95.3	6.8543	57.2389
2025	10	30	17	32	15	26.87	96.4	6.8604	61.188
2025	10	30	17	42	15	25.09	97.1	6.8543	57.0099
2025	10	30	17	52	15	25.71	97.4	6.8604	58.4381
2025	10	30	18	2	15	25.28	96.8	6.8604	57.5214
2025	10	30	18	12	15	25.71	97.4	6.8543	58.3837
2025	10	30	18	22	15	25.36	100.9	6.8543	57.01
2025	10	30	18	32	15	25.92	95.5	6.8543	59.0706
2025	10	30	18	42	15	25.37	98.4	6.8604	57.5215
2025	10	30	18	52	15	25.8	97.1	6.8604	58.6673
2025	10	30	19	2	15	26.1	97	6.8604	59.3549
2025	10	30	19	12	15	26.37	96.5	6.8604	60.0424
2025	10	30	19	22	15	24.97	94.4	6.8604	57.0632
2025	10	30	19	32	15	26.54	95.8	6.8604	60.5008
2025	10	30	19	42	15	24.35	98.3	6.8604	55.2299
2025	10	30	19	52	15	24.25	96.4	6.8665	55.2813
2025	10	30	20	2	15	24.78	97	6.8665	56.4282
2025	10	30	20	12	15	24.13	95.9	6.8604	55.0008
2025	10	30	20	22	15	24.72	95.6	6.8665	56.4283
2025	10	30	20	32	15	24.56	96.5	6.8726	56.0215
2025	10	30	20	42	15	25.93	95.8	6.8726	59.2359
2025	10	30	20	52	15	25.24	96.1	6.8726	57.6288
2025	10	30	21	2	15	24.79	94.9	6.8726	56.7104
2025	10	30	21	12	15	25.3	97.3	6.8726	57.6288
2025	10	30	21	22	15	25.58	96.7	6.8726	58.3176
2025	10	30	21	32	15	24.81	95.3	6.8726	56.7105
2025	10	30	21	42	15	24.05	96.4	6.8726	54.8737
2025	10	30	21	52	15	26.1	97	6.8726	59.4657
2025	10	30	22	2	15	24.13	97.9	6.8726	54.8738
2025	10	30	22	12	15	25.22	95.7	6.8726	57.629
2025	10	30	22	22	15	25.28	96.8	6.8787	57.6825
2025	10	30	22	32	15	24.86	96.5	6.8787	56.7633
2025	10	30	22	42	15	25.59	94.7	6.8726	58.5474
2025	10	30	22	52	15	23.84	96.3	6.8726	54.4147
2025	10	30	23	2	15	25.2	95	6.8726	57.6291
2025	10	30	23	12	15	24.87	96.7	6.8787	56.7634
2025	10	30	23	22	15	26.01	95.3	6.8787	59.5211
2025	10	30	23	32	15	25.3	97.3	6.8726	57.6291
2025	10	30	23	42	15	23.89	95	6.8787	54.6951
2025	10	30	23	52	15	25.23	97.7	6.8787	57.4528

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	31	0	2	15	24.81	99	6.8787	56.3038
2025	10	31	0	12	15	24.17	96.9	6.8787	55.1547
2025	10	31	0	22	15	25.49	97	6.8787	58.1423
2025	10	31	0	32	15	25.34	96.1	6.8787	57.9125
2025	10	31	0	42	15	25.6	97.2	6.8787	58.3721
2025	10	31	0	52	15	24.47	98.5	6.8787	55.6144
2025	10	31	1	2	15	25.96	96.4	6.8787	59.2914
2025	10	31	1	12	15	23.89	100.4	6.8787	54.0057
2025	10	31	1	22	15	25.38	96.8	6.8787	57.9125
2025	10	31	1	32	15	25.26	96.4	6.8787	57.6827
2025	10	31	1	42	15	24.27	96.9	6.8787	55.3846
2025	10	31	1	52	15	25.25	99.6	6.8787	57.2231
2025	10	31	2	2	15	23.69	97.3	6.8787	54.0058
2025	10	31	2	12	15	25	95	6.8787	57.2231
2025	10	31	2	22	15	25.07	96.6	6.8787	57.2231
2025	10	31	2	32	15	25.69	96.9	6.8787	58.602
2025	10	31	2	42	15	26.57	98.2	6.8787	60.4405
2025	10	31	2	52	15	25.75	96.2	6.8787	58.8318
2025	10	31	3	2	15	25.52	95.6	6.8787	58.3722
2025	10	31	3	12	15	26.08	96.8	6.8787	59.5212
2025	10	31	3	22	15	25.15	93.6	6.8787	57.6827
2025	10	31	3	32	15	25.12	95.7	6.8787	57.4529
2025	10	31	3	42	15	26.43	95.6	6.8787	60.4405
2025	10	31	3	52	15	25.4	95.2	6.8787	58.1424
2025	10	31	4	2	15	25.39	98.6	6.8787	57.6827
2025	10	31	4	12	15	23.87	94.3	6.8787	54.6952
2025	10	31	4	22	15	26.69	96.9	6.8787	60.9001
2025	10	31	4	32	15	24.42	95.6	6.8787	55.8442
2025	10	31	4	42	15	25.84	96	6.8787	59.0616
2025	10	31	4	52	15	25.17	96.6	6.8787	57.4529
2025	10	31	5	2	15	25.74	97.8	6.8787	58.6019
2025	10	31	5	12	15	26.09	94.8	6.8787	59.751
2025	10	31	5	22	15	25.21	95.2	6.8787	57.6827
2025	10	31	5	32	15	25.9	95.1	6.8787	59.2914
2025	10	31	5	42	15	25.22	95.7	6.8787	57.6827
2025	10	31	5	52	15	26.22	99	6.8787	59.5212
2025	10	31	6	2	15	25.33	97.7	6.8848	57.7362
2025	10	31	6	12	15	25.66	96.5	6.8787	58.6019
2025	10	31	6	22	15	26.01	97.3	6.8787	59.2914
2025	10	31	6	32	15	25.16	96.4	6.8848	57.5061
2025	10	31	6	42	15	25.21	95.2	6.8787	57.6827
2025	10	31	6	52	15	24.91	95.3	6.8848	57.0461
2025	10	31	7	2	15	25.31	95.4	6.8848	57.9662
2025	10	31	7	12	15	25.27	96.6	6.8848	57.7362
2025	10	31	7	22	15	24.47	96.8	6.8848	55.896
2025	10	31	7	32	15	25.3	97.3	6.8848	57.7362
2025	10	31	7	42	15	24.25	96.4	6.8848	55.4359
2025	10	31	7	52	15	25.52	95.6	6.8848	58.4262

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	31	8	2	15	25.24	96.1	6.8848	57.7361
2025	10	31	8	12	15	25.02	95.5	6.8848	57.2761
2025	10	31	8	22	15	24.57	96.8	6.8848	56.1259
2025	10	31	8	32	15	25.27	96.6	6.8848	57.7361
2025	10	31	8	42	15	26.8	97.1	6.8848	61.1864
2025	10	31	8	52	15	23.62	97.8	6.8848	53.8256
2025	10	31	9	2	15	25.33	95.9	6.8848	57.966
2025	10	31	9	12	15	24.95	96.2	6.8848	57.0459
2025	10	31	9	22	15	25	95	6.8848	57.2759
2025	10	31	9	32	15	24.66	96.5	6.8848	56.3557
2025	10	31	9	42	15	25.4	97.2	6.8848	57.9659
2025	10	31	9	52	15	26.41	97.2	6.8848	60.2661
2025	10	31	10	2	15	25.48	96.8	6.8848	58.1958
2025	10	31	10	12	15	24.48	94.7	6.8848	56.1256
2025	10	31	10	22	15	25.11	95.3	6.8848	57.5057
2025	10	31	10	32	15	26.53	99.1	6.8848	60.2659
2025	10	31	10	42	15	26.38	98.3	6.8848	60.0359
2025	10	31	10	52	15	24.2	97.4	6.8848	55.2054
2025	10	31	11	2	15	24.53	95.9	6.8848	56.1254
2025	10	31	11	12	15	25.68	96.7	6.8848	58.6556
2025	10	31	11	22	15	25.09	94.8	6.8848	57.5055
2025	10	31	11	32	15	26.12	95.5	6.8848	59.8057
2025	10	31	11	42	15	24.29	97.1	6.8848	55.4352
2025	10	31	11	52	15	25.69	96.9	6.8848	58.6555
2025	10	31	12	2	15	25.75	98	6.8848	58.6555
2025	10	31	12	12	15	25.48	96.8	6.8848	58.1954
2025	10	31	12	22	15	25.3	97.3	6.8848	57.7353
2025	10	31	12	32	15	25.91	98.9	6.8848	58.8854
2025	10	31	12	42	15	25.96	96.4	6.8848	59.3455
2025	10	31	12	52	15	26.19	98.6	6.8848	59.5755
2025	10	31	13	2	15	24.88	96.9	6.8848	56.8152
2025	10	31	13	12	15	24.51	97.5	6.8787	55.8433
2025	10	31	13	22	15	25.76	96.5	6.8787	58.8308
2025	10	31	13	32	15	23.87	98.7	6.8787	54.2346
2025	10	31	13	42	15	24.45	98.2	6.8787	55.6135
2025	10	31	13	52	15	25.5	98.8	6.8726	57.8578
2025	10	31	14	2	15	24.95	96.2	6.8726	56.9394
2025	10	31	14	12	15	24.75	96.3	6.8665	56.4278
2025	10	31	14	22	15	24.26	96.6	6.8726	55.3323
2025	10	31	14	32	15	24.26	94	6.8665	55.5103
2025	10	31	14	42	15	25.68	96.7	6.8665	58.4923
2025	10	31	14	52	15	24.18	94.7	6.8665	55.2809
2025	10	31	15	2	15	23.64	96.3	6.8665	53.9046
2025	10	31	15	12	15	23.93	97.9	6.8604	54.3129
2025	10	31	15	22	15	24.36	96.6	6.8604	55.4588
2025	10	31	15	32	15	23.35	93.7	6.8604	53.3963
2025	10	31	15	42	15	25.65	96.3	6.8543	58.3837
2025	10	31	15	52	15	25.43	97.7	6.8604	57.7505

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	10	31	16	2	15	24.01	95.5	6.8543	54.7204
2025	10	31	16	12	15	25.15	96.2	6.8543	57.2389
2025	10	31	16	22	15	25.18	96.8	6.8543	57.239
2025	10	31	16	32	15	24.71	99.1	6.8543	55.8652
2025	10	31	16	42	15	25.7	100.1	6.8543	57.9258
2025	10	31	16	52	15	25.54	96.1	6.8543	58.1548
2025	10	31	17	2	15	25.09	98.7	6.8543	56.7811
2025	10	31	17	12	15	25.55	96.3	6.8543	58.1548
2025	10	31	17	22	15	25.88	98.4	6.8543	58.6127
2025	10	31	17	32	15	24.69	94.9	6.8543	56.3232
2025	10	31	17	42	15	26.38	96.7	6.8543	59.9865
2025	10	31	17	52	15	25.71	97.4	6.8543	58.3838
2025	10	31	18	2	15	24.39	94.9	6.8543	55.6363
2025	10	31	18	12	15	25.2	95	6.8543	57.468
2025	10	31	18	22	15	25.65	96.3	6.8543	58.3838
2025	10	31	18	32	15	25.09	97.1	6.8543	57.0101
2025	10	31	18	42	15	24.34	96.1	6.8543	55.4075
2025	10	31	18	52	15	24.68	97	6.8543	56.0943
2025	10	31	19	2	15	25.72	95.6	6.8543	58.6129
2025	10	31	19	12	15	23.86	98.4	6.8543	54.0338
2025	10	31	19	22	15	25.13	97.8	6.8543	57.0102
2025	10	31	19	32	15	24.64	96.1	6.8482	56.0422
2025	10	31	19	42	15	24.56	96.5	6.8543	55.8655
2025	10	31	19	52	15	24.25	96.4	6.8482	55.1273
2025	10	31	20	2	15	25.63	99.2	6.8482	57.8722
2025	10	31	20	12	15	26.78	96.6	6.8482	60.8459
2025	10	31	20	22	15	24.55	96.3	6.8482	55.8136
2025	10	31	20	32	15	25.95	96.2	6.8543	59.071
2025	10	31	20	42	15	25.02	95.5	6.8482	56.9573
2025	10	31	20	52	15	24.63	95.8	6.8482	56.0424
2025	10	31	21	2	15	25.74	96	6.8482	58.5586
2025	10	31	21	12	15	25.69	96.9	6.8482	58.3299
2025	10	31	21	22	15	25.68	96.7	6.8482	58.3299
2025	10	31	21	32	15	25.52	95.6	6.8482	58.1012
2025	10	31	21	42	15	25.78	96.7	6.8482	58.5587
2025	10	31	21	52	15	25.05	96.2	6.8482	56.9575
2025	10	31	22	2	15	25.27	96.6	6.8482	57.415
2025	10	31	22	12	15	25.52	95.6	6.8421	58.0471
2025	10	31	22	22	15	25.28	96.8	6.8482	57.415
2025	10	31	22	32	15	25.39	98.6	6.8421	57.3616
2025	10	31	22	42	15	25.38	96.8	6.8482	57.6438
2025	10	31	22	52	15	25.63	95.8	6.8421	58.2757
2025	10	31	23	2	15	25.9	97.1	6.8421	58.7328
2025	10	31	23	12	15	25.81	95.3	6.8482	58.7876
2025	10	31	23	22	15	25.81	97.3	6.8421	58.5043
2025	10	31	23	32	15	24.96	96.4	6.8421	56.6761
2025	10	31	23	42	15	25.29	97	6.8421	57.3617
2025	10	31	23	52	15	25.38	96.8	6.8421	57.5902

Alabama Gates Release

Station 0087

Date	Flow (cfs)
10/1/2025	0.00
10/2/2025	0.00
10/3/2025	0.00
10/4/2025	0.00
10/5/2025	0.00
10/6/2025	0.00
10/7/2025	0.00
10/8/2025	0.00
10/9/2025	0.00
10/10/2025	0.00
10/11/2025	0.00
10/12/2025	0.00
10/13/2025	0.00
10/14/2025	0.00
10/15/2025	0.00
10/16/2025	0.00
10/17/2025	0.00
10/18/2025	0.00
10/19/2025	0.00
10/20/2025	0.00
10/21/2025	0.00
10/22/2025	0.00
10/23/2025	0.00
10/24/2025	0.00
10/25/2025	0.00
10/26/2025	0.00
10/27/2025	0.00
10/28/2025	0.00
10/29/2025	0.00
10/30/2025	0.00
10/31/2025	0.00

Langemann Gate to Delta Weir to Delta Pumpback Station Discharge

DATE	FLOW (CFS)	FLOW (CFS)	FLOW (CFS)
10/1/2025	11	0	46
10/2/2025	11	0	46
10/3/2025	11	0	45
10/4/2025	11	0	45
10/5/2025	11	0	45
10/6/2025	11	0	47
10/7/2025	11	0	47
10/8/2025	11	0	47
10/9/2025	11	0	47
10/10/2025	11	0	46
10/11/2025	11	0	45
10/12/2025	11	0	44
10/13/2025	11	0	46
10/14/2025	11	0	47
10/15/2025	11	0	48
10/16/2025	9	4	48
10/17/2025	8	10	48
10/18/2025	8	6	48
10/19/2025	8	4	48
10/20/2025	8	3	48
10/21/2025	8	3	48
10/22/2025	8	4	48
10/23/2025	8	2	48
10/24/2025	8	1	48
10/25/2025	8	0	48
10/26/2025	8	0	45
10/27/2025	8	0	42
10/28/2025	8	0	41
10/29/2025	8	0	40
10/30/2025	8	0	40
10/31/2025	8	0	40

Pumpback Station Discharge (0364)

10/1/25 0:00 == 48.1	10/1/25 4:30 == 48	10/1/25 9:00 == 48.1	10/1/25 13:30 == 47.9
10/1/25 0:05 == 48	10/1/25 4:35 == 48	10/1/25 9:05 == 48.1	10/1/25 13:35 == 48
10/1/25 0:10 == 47.6	10/1/25 4:40 == 48	10/1/25 9:10 == 48	10/1/25 13:40 == 48
10/1/25 0:15 == 47.9	10/1/25 4:45 == 48	10/1/25 9:15 == 48.2	10/1/25 13:45 == 48
10/1/25 0:20 == 48	10/1/25 4:50 == 48.1	10/1/25 9:20 == 48	10/1/25 13:50 == 48
10/1/25 0:25 == 48	10/1/25 4:55 == 48.2	10/1/25 9:25 == 48	10/1/25 13:55 == 48
10/1/25 0:30 == 47.9	10/1/25 5:00 == 48	10/1/25 9:30 == 47.8	10/1/25 14:00 == 48.1
10/1/25 0:35 == 47.9	10/1/25 5:05 == 48	10/1/25 9:35 == 48	10/1/25 14:05 == 47.9
10/1/25 0:40 == 48	10/1/25 5:10 == 47.5	10/1/25 9:40 == 47.9	10/1/25 14:10 == 48
10/1/25 0:45 == 47.9	10/1/25 5:15 == 47.8	10/1/25 9:45 == 48	10/1/25 14:15 == 48
10/1/25 0:50 == 47.9	10/1/25 5:20 == 48	10/1/25 9:50 == 48	10/1/25 14:20 == 48
10/1/25 0:55 == 47.9	10/1/25 5:25 == 47.8	10/1/25 9:55 == 47.8	10/1/25 14:25 == 48.2
10/1/25 1:00 == 48.1	10/1/25 5:30 == 48	10/1/25 10:00 == 48.1	10/1/25 14:30 == 48.1
10/1/25 1:05 == 48.1	10/1/25 5:35 == 48	10/1/25 10:05 == 48.2	10/1/25 14:35 == 48.1
10/1/25 1:10 == 48.1	10/1/25 5:40 == 48	10/1/25 10:10 == 48	10/1/25 14:40 == 48.2
10/1/25 1:15 == 47.9	10/1/25 5:45 == 47.9	10/1/25 10:15 == 47.9	10/1/25 14:45 == 48.1
10/1/25 1:20 == 47.8	10/1/25 5:50 == 48	10/1/25 10:20 == 48	10/1/25 14:50 == 47.9
10/1/25 1:25 == 47.7	10/1/25 5:55 == 47.6	10/1/25 10:25 == 48	10/1/25 14:55 == 47.9
10/1/25 1:30 == 47.9	10/1/25 6:00 == 47.6	10/1/25 10:30 == 48.1	10/1/25 15:00 == 48.1
10/1/25 1:35 == 47.9	10/1/25 6:05 == 48	10/1/25 10:35 == 48	10/1/25 15:05 == 47.3
10/1/25 1:40 == 48.1	10/1/25 6:10 == 47.8	10/1/25 10:40 == 47.6	10/1/25 15:10 == 47.9
10/1/25 1:45 == 48.2	10/1/25 6:15 == 47.7	10/1/25 10:45 == 47.8	10/1/25 15:15 == 48
10/1/25 1:50 == 48	10/1/25 6:20 == 47.9	10/1/25 10:50 == 48.1	10/1/25 15:20 == 48
10/1/25 1:55 == 47.9	10/1/25 6:25 == 48	10/1/25 10:55 == 47.7	10/1/25 15:25 == 47.4
10/1/25 2:00 == 47.5	10/1/25 6:30 == 48.1	10/1/25 11:00 == 47.8	10/1/25 15:30 == 48
10/1/25 2:05 == 47.8	10/1/25 6:35 == 47.8	10/1/25 11:05 == 48	10/1/25 15:35 == 48.1
10/1/25 2:10 == 48	10/1/25 6:40 == 47.6	10/1/25 11:10 == 48	10/1/25 15:40 == 47.9
10/1/25 2:15 == 47.7	10/1/25 6:45 == 47.7	10/1/25 11:15 == 48	10/1/25 15:45 == 48.1
10/1/25 2:20 == 47.9	10/1/25 6:50 == 47.9	10/1/25 11:20 == 47.7	10/1/25 15:50 == 48.1
10/1/25 2:25 == 47.4	10/1/25 6:55 == 47.6	10/1/25 11:25 == 47.6	10/1/25 15:55 == 48
10/1/25 2:30 == 48	10/1/25 7:00 == 47.9	10/1/25 11:30 == 47.9	10/1/25 16:00 == 48
10/1/25 2:35 == 48.1	10/1/25 7:05 == 47.9	10/1/25 11:35 == 47.9	10/1/25 16:05 == 48
10/1/25 2:40 == 48	10/1/25 7:10 == 48.1	10/1/25 11:40 == 44	10/1/25 16:10 == 48.1
10/1/25 2:45 == 48	10/1/25 7:15 == 48	10/1/25 11:45 == 35.4	10/1/25 16:15 == 48
10/1/25 2:50 == 47.9	10/1/25 7:20 == 48	10/1/25 11:50 == 34.1	10/1/25 16:20 == 48
10/1/25 2:55 == 48.1	10/1/25 7:25 == 47.8	10/1/25 11:55 == 34	10/1/25 16:25 == 43.5
10/1/25 3:00 == 48	10/1/25 7:30 == 47.9	10/1/25 12:00 == 33.9	10/1/25 16:30 == 36.8
10/1/25 3:05 == 47.9	10/1/25 7:35 == 47.9	10/1/25 12:05 == 33.8	10/1/25 16:35 == 34.2
10/1/25 3:10 == 41.9	10/1/25 7:40 == 42.9	10/1/25 12:10 == 35.4	10/1/25 16:40 == 33.9
10/1/25 3:15 == 36	10/1/25 7:45 == 35.2	10/1/25 12:15 == 46.7	10/1/25 16:45 == 33.7
10/1/25 3:20 == 34.6	10/1/25 7:50 == 34	10/1/25 12:20 == 48	10/1/25 16:50 == 33.7
10/1/25 3:25 == 34.6	10/1/25 7:55 == 33.9	10/1/25 12:25 == 48	10/1/25 16:55 == 36.2
10/1/25 3:30 == 34.6	10/1/25 8:00 == 33.8	10/1/25 12:30 == 48	10/1/25 17:00 == 43.9
10/1/25 3:35 == 34.5	10/1/25 8:05 == 33.9	10/1/25 12:35 == 47.9	10/1/25 17:05 == 47.5
10/1/25 3:40 == 38.3	10/1/25 8:10 == 37.7	10/1/25 12:40 == 48	10/1/25 17:10 == 47.3
10/1/25 3:45 == 45.3	10/1/25 8:15 == 45	10/1/25 12:45 == 48.1	10/1/25 17:15 == 48
10/1/25 3:50 == 47.9	10/1/25 8:20 == 48.1	10/1/25 12:50 == 48	10/1/25 17:20 == 48.1
10/1/25 3:55 == 48	10/1/25 8:25 == 48	10/1/25 12:55 == 48	10/1/25 17:25 == 47.8
10/1/25 4:00 == 48	10/1/25 8:30 == 48	10/1/25 13:00 == 48	10/1/25 17:30 == 48
10/1/25 4:05 == 48.1	10/1/25 8:35 == 48	10/1/25 13:05 == 48	10/1/25 17:35 == 48
10/1/25 4:10 == 48	10/1/25 8:40 == 47.9	10/1/25 13:10 == 48.1	10/1/25 17:40 == 48.2
10/1/25 4:15 == 48.1	10/1/25 8:45 == 48	10/1/25 13:15 == 48	10/1/25 17:45 == 47.8
10/1/25 4:20 == 48	10/1/25 8:50 == 48	10/1/25 13:20 == 48	10/1/25 17:50 == 48
10/1/25 4:25 == 48.2	10/1/25 8:55 == 47.9	10/1/25 13:25 == 48	10/1/25 17:55 == 48

Pumpback Station Discharge (0364)

10/1/25 18:00 == 48	10/1/25 22:30 == 48.1	10/2/25 3:00 == 48.1	10/2/25 7:30 == 34.1
10/1/25 18:05 == 48	10/1/25 22:35 == 47.9	10/2/25 3:05 == 48.1	10/2/25 7:35 == 34.1
10/1/25 18:10 == 48	10/1/25 22:40 == 48	10/2/25 3:10 == 48.1	10/2/25 7:40 == 34.2
10/1/25 18:15 == 48.1	10/1/25 22:45 == 47.9	10/2/25 3:15 == 47.9	10/2/25 7:45 == 34.3
10/1/25 18:20 == 48	10/1/25 22:50 == 47.9	10/2/25 3:20 == 48	10/2/25 7:50 == 34.2
10/1/25 18:25 == 48	10/1/25 22:55 == 48.1	10/2/25 3:25 == 48	10/2/25 7:55 == 35.9
10/1/25 18:30 == 47.9	10/1/25 23:00 == 48.1	10/2/25 3:30 == 47.9	10/2/25 8:00 == 42.5
10/1/25 18:35 == 48	10/1/25 23:05 == 48	10/2/25 3:35 == 48	10/2/25 8:05 == 48
10/1/25 18:40 == 48	10/1/25 23:10 == 48.1	10/2/25 3:40 == 46.3	10/2/25 8:10 == 48
10/1/25 18:45 == 48	10/1/25 23:15 == 47.9	10/2/25 3:45 == 35.4	10/2/25 8:15 == 48.1
10/1/25 18:50 == 48	10/1/25 23:20 == 47.9	10/2/25 3:50 == 33.8	10/2/25 8:20 == 47.9
10/1/25 18:55 == 47.9	10/1/25 23:25 == 48.1	10/2/25 3:55 == 33.7	10/2/25 8:25 == 47.7
10/1/25 19:00 == 47.8	10/1/25 23:30 == 48.1	10/2/25 4:00 == 33.5	10/2/25 8:30 == 47.9
10/1/25 19:05 == 47.8	10/1/25 23:35 == 48	10/2/25 4:05 == 33.6	10/2/25 8:35 == 48
10/1/25 19:10 == 47.9	10/1/25 23:40 == 47.9	10/2/25 4:10 == 33.7	10/2/25 8:40 == 48
10/1/25 19:15 == 48	10/1/25 23:45 == 48.1	10/2/25 4:15 == 45.1	10/2/25 8:45 == 48.1
10/1/25 19:20 == 48	10/1/25 23:50 == 48	10/2/25 4:20 == 47.6	10/2/25 8:50 == 48
10/1/25 19:25 == 48	10/1/25 23:55 == 48	10/2/25 4:25 == 48	10/2/25 8:55 == 48.1
10/1/25 19:30 == 48	10/2/25 0:00 == 48	10/2/25 4:30 == 48.1	10/2/25 9:00 == 48.1
10/1/25 19:35 == 47.9	10/2/25 0:05 == 48	10/2/25 4:35 == 48.1	10/2/25 9:05 == 48.1
10/1/25 19:40 == 48	10/2/25 0:10 == 43.9	10/2/25 4:40 == 48.1	10/2/25 9:10 == 48.1
10/1/25 19:45 == 47.9	10/2/25 0:15 == 37.1	10/2/25 4:45 == 48.1	10/2/25 9:15 == 48.1
10/1/25 19:50 == 48	10/2/25 0:20 == 34.2	10/2/25 4:50 == 48	10/2/25 9:20 == 48.1
10/1/25 19:55 == 48	10/2/25 0:25 == 34.2	10/2/25 4:55 == 47.9	10/2/25 9:25 == 48
10/1/25 20:00 == 48.2	10/2/25 0:30 == 34.1	10/2/25 5:00 == 47.9	10/2/25 9:30 == 47.9
10/1/25 20:05 == 48	10/2/25 0:35 == 34.2	10/2/25 5:05 == 47.9	10/2/25 9:35 == 48
10/1/25 20:10 == 46	10/2/25 0:40 == 36.6	10/2/25 5:10 == 47.7	10/2/25 9:40 == 48
10/1/25 20:15 == 34.9	10/2/25 0:45 == 43.8	10/2/25 5:15 == 47.7	10/2/25 9:45 == 47.9
10/1/25 20:20 == 35	10/2/25 0:50 == 47.9	10/2/25 5:20 == 47.9	10/2/25 9:50 == 47.9
10/1/25 20:25 == 34.9	10/2/25 0:55 == 47.5	10/2/25 5:25 == 47.9	10/2/25 9:55 == 48.1
10/1/25 20:30 == 35.1	10/2/25 1:00 == 48	10/2/25 5:30 == 47.9	10/2/25 10:00 == 47.9
10/1/25 20:35 == 34.9	10/2/25 1:05 == 47.9	10/2/25 5:35 == 48	10/2/25 10:05 == 48
10/1/25 20:40 == 36.1	10/2/25 1:10 == 48	10/2/25 5:40 == 48	10/2/25 10:10 == 48.1
10/1/25 20:45 == 45.9	10/2/25 1:15 == 48.2	10/2/25 5:45 == 47.8	10/2/25 10:15 == 48.1
10/1/25 20:50 == 47.9	10/2/25 1:20 == 48.1	10/2/25 5:50 == 47.9	10/2/25 10:20 == 48.1
10/1/25 20:55 == 47.7	10/2/25 1:25 == 48.1	10/2/25 5:55 == 48	10/2/25 10:25 == 48.2
10/1/25 21:00 == 47.9	10/2/25 1:30 == 48	10/2/25 6:00 == 48	10/2/25 10:30 == 48.1
10/1/25 21:05 == 48.1	10/2/25 1:35 == 48.1	10/2/25 6:05 == 47.9	10/2/25 10:35 == 48
10/1/25 21:10 == 47.9	10/2/25 1:40 == 47.9	10/2/25 6:10 == 47.8	10/2/25 10:40 == 45.3
10/1/25 21:15 == 47.9	10/2/25 1:45 == 48.1	10/2/25 6:15 == 47.9	10/2/25 10:45 == 38.9
10/1/25 21:20 == 48.1	10/2/25 1:50 == 48.1	10/2/25 6:20 == 47.9	10/2/25 10:50 == 34.9
10/1/25 21:25 == 48	10/2/25 1:55 == 48.1	10/2/25 6:25 == 48.1	10/2/25 10:55 == 35.1
10/1/25 21:30 == 47.9	10/2/25 2:00 == 48.1	10/2/25 6:30 == 48.1	10/2/25 11:00 == 35
10/1/25 21:35 == 48	10/2/25 2:05 == 48	10/2/25 6:35 == 48	10/2/25 11:05 == 34.9
10/1/25 21:40 == 47.9	10/2/25 2:10 == 48	10/2/25 6:40 == 48.1	10/2/25 11:10 == 36.1
10/1/25 21:45 == 47.9	10/2/25 2:15 == 48	10/2/25 6:45 == 47.5	10/2/25 11:15 == 42.4
10/1/25 21:50 == 47.9	10/2/25 2:20 == 48.1	10/2/25 6:50 == 48	10/2/25 11:20 == 47.5
10/1/25 21:55 == 47.9	10/2/25 2:25 == 47.7	10/2/25 6:55 == 47.6	10/2/25 11:25 == 48
10/1/25 22:00 == 48	10/2/25 2:30 == 47.7	10/2/25 7:00 == 47.9	10/2/25 11:30 == 48.1
10/1/25 22:05 == 48	10/2/25 2:35 == 47.9	10/2/25 7:05 == 48	10/2/25 11:35 == 48
10/1/25 22:10 == 48.1	10/2/25 2:40 == 47.9	10/2/25 7:10 == 46	10/2/25 11:40 == 48.1
10/1/25 22:15 == 47.9	10/2/25 2:45 == 48.1	10/2/25 7:15 == 37.4	10/2/25 11:45 == 47.8
10/1/25 22:20 == 48	10/2/25 2:50 == 48.1	10/2/25 7:20 == 34.7	10/2/25 11:50 == 48.1
10/1/25 22:25 == 47.9	10/2/25 2:55 == 48	10/2/25 7:25 == 34.5	10/2/25 11:55 == 47.4

Pumpback Station Discharge (0364)

10/2/25 12:00 == 47.9	10/2/25 16:30 == 48	10/2/25 21:00 == 47.9	10/3/25 1:30 == 48.1
10/2/25 12:05 == 48.2	10/2/25 16:35 == 48.1	10/2/25 21:05 == 48	10/3/25 1:35 == 47.8
10/2/25 12:10 == 47.6	10/2/25 16:40 == 47.1	10/2/25 21:10 == 48.1	10/3/25 1:40 == 46.9
10/2/25 12:15 == 48	10/2/25 16:45 == 37.7	10/2/25 21:15 == 48.1	10/3/25 1:45 == 39.4
10/2/25 12:20 == 47.9	10/2/25 16:50 == 34.1	10/2/25 21:20 == 47.9	10/3/25 1:50 == 34.6
10/2/25 12:25 == 48	10/2/25 16:55 == 34.1	10/2/25 21:25 == 48	10/3/25 1:55 == 34.5
10/2/25 12:30 == 48.1	10/2/25 17:00 == 34.1	10/2/25 21:30 == 48	10/3/25 2:00 == 34.6
10/2/25 12:35 == 48.2	10/2/25 17:05 == 34.1	10/2/25 21:35 == 47.9	10/3/25 2:05 == 34.7
10/2/25 12:40 == 48	10/2/25 17:10 == 34.1	10/2/25 21:40 == 47.8	10/3/25 2:10 == 34.3
10/2/25 12:45 == 48	10/2/25 17:15 == 43.2	10/2/25 21:45 == 48	10/3/25 2:15 == 33.9
10/2/25 12:50 == 48	10/2/25 17:20 == 47.4	10/2/25 21:50 == 48	10/3/25 2:20 == 34
10/2/25 12:55 == 48	10/2/25 17:25 == 47.7	10/2/25 21:55 == 48.1	10/3/25 2:25 == 35
10/2/25 13:00 == 48.1	10/2/25 17:30 == 47.8	10/2/25 22:00 == 48	10/3/25 2:30 == 39.9
10/2/25 13:05 == 47.9	10/2/25 17:35 == 47.8	10/2/25 22:05 == 48.1	10/3/25 2:35 == 48.1
10/2/25 13:10 == 48	10/2/25 17:40 == 48	10/2/25 22:10 == 48.2	10/3/25 2:40 == 48
10/2/25 13:15 == 48.1	10/2/25 17:45 == 48	10/2/25 22:15 == 47.9	10/3/25 2:45 == 48
10/2/25 13:20 == 48.1	10/2/25 17:50 == 48	10/2/25 22:20 == 47.9	10/3/25 2:50 == 48
10/2/25 13:25 == 47.9	10/2/25 17:55 == 48.1	10/2/25 22:25 == 48	10/3/25 2:55 == 48
10/2/25 13:30 == 47.8	10/2/25 18:00 == 48	10/2/25 22:30 == 48	10/3/25 3:00 == 48.1
10/2/25 13:35 == 47.5	10/2/25 18:05 == 48	10/2/25 22:35 == 48	10/3/25 3:05 == 48
10/2/25 13:40 == 47.9	10/2/25 18:10 == 48	10/2/25 22:40 == 48	10/3/25 3:10 == 48
10/2/25 13:45 == 48	10/2/25 18:15 == 48	10/2/25 22:45 == 37.7	10/3/25 3:15 == 48.1
10/2/25 13:50 == 48	10/2/25 18:20 == 48.1	10/2/25 22:50 == 34.3	10/3/25 3:20 == 48.2
10/2/25 13:55 == 47.8	10/2/25 18:25 == 48	10/2/25 22:55 == 34.3	10/3/25 3:25 == 47.6
10/2/25 14:00 == 48	10/2/25 18:30 == 47.9	10/2/25 23:00 == 34.4	10/3/25 3:30 == 47.9
10/2/25 14:05 == 47.8	10/2/25 18:35 == 48	10/2/25 23:05 == 34.4	10/3/25 3:35 == 48.1
10/2/25 14:10 == 47.3	10/2/25 18:40 == 48	10/2/25 23:10 == 34.3	10/3/25 3:40 == 47.8
10/2/25 14:15 == 36.8	10/2/25 18:45 == 48	10/2/25 23:15 == 41.7	10/3/25 3:45 == 47.7
10/2/25 14:20 == 34	10/2/25 18:50 == 48	10/2/25 23:20 == 47.9	10/3/25 3:50 == 48.1
10/2/25 14:25 == 34	10/2/25 18:55 == 47.9	10/2/25 23:25 == 47.9	10/3/25 3:55 == 48.1
10/2/25 14:30 == 34.2	10/2/25 19:00 == 48	10/2/25 23:30 == 47.8	10/3/25 4:00 == 48
10/2/25 14:35 == 34.5	10/2/25 19:05 == 48.1	10/2/25 23:35 == 48.1	10/3/25 4:05 == 48
10/2/25 14:40 == 34.5	10/2/25 19:10 == 48.1	10/2/25 23:40 == 48.1	10/3/25 4:10 == 48
10/2/25 14:45 == 43.5	10/2/25 19:15 == 48	10/2/25 23:45 == 48	10/3/25 4:15 == 48
10/2/25 14:50 == 47.4	10/2/25 19:20 == 48.1	10/2/25 23:50 == 47.9	10/3/25 4:20 == 48
10/2/25 14:55 == 48	10/2/25 19:25 == 47.7	10/2/25 23:55 == 47.8	10/3/25 4:25 == 48
10/2/25 15:00 == 48	10/2/25 19:30 == 37.3	10/3/25 0:00 == 48	10/3/25 4:30 == 48.2
10/2/25 15:05 == 48	10/2/25 19:35 == 34.5	10/3/25 0:05 == 47.9	10/3/25 4:35 == 48.1
10/2/25 15:10 == 47.5	10/2/25 19:40 == 34.4	10/3/25 0:10 == 47.6	10/3/25 4:40 == 48
10/2/25 15:15 == 47.6	10/2/25 19:45 == 34.3	10/3/25 0:15 == 47.8	10/3/25 4:45 == 48
10/2/25 15:20 == 47.9	10/2/25 19:50 == 34.5	10/3/25 0:20 == 48.1	10/3/25 4:50 == 47.9
10/2/25 15:25 == 48	10/2/25 19:55 == 34.5	10/3/25 0:25 == 47.9	10/3/25 4:55 == 47.9
10/2/25 15:30 == 48	10/2/25 20:00 == 43.2	10/3/25 0:30 == 48	10/3/25 5:00 == 47.9
10/2/25 15:35 == 47.9	10/2/25 20:05 == 47.3	10/3/25 0:35 == 48	10/3/25 5:05 == 48
10/2/25 15:40 == 47.9	10/2/25 20:10 == 47.6	10/3/25 0:40 == 47.9	10/3/25 5:10 == 48.1
10/2/25 15:45 == 47.9	10/2/25 20:15 == 47.8	10/3/25 0:45 == 48	10/3/25 5:15 == 48
10/2/25 15:50 == 48	10/2/25 20:20 == 47.9	10/3/25 0:50 == 47.8	10/3/25 5:20 == 48.1
10/2/25 15:55 == 47.9	10/2/25 20:25 == 47.9	10/3/25 0:55 == 47.9	10/3/25 5:25 == 48
10/2/25 16:00 == 48	10/2/25 20:30 == 48	10/3/25 1:00 == 48	10/3/25 5:30 == 48
10/2/25 16:05 == 48.1	10/2/25 20:35 == 48	10/3/25 1:05 == 48	10/3/25 5:35 == 48.1
10/2/25 16:10 == 48	10/2/25 20:40 == 48	10/3/25 1:10 == 48	10/3/25 5:40 == 47.4
10/2/25 16:15 == 48	10/2/25 20:45 == 48	10/3/25 1:15 == 48	10/3/25 5:45 == 39.8
10/2/25 16:20 == 48.1	10/2/25 20:50 == 48	10/3/25 1:20 == 48.1	10/3/25 5:50 == 34.2
10/2/25 16:25 == 48	10/2/25 20:55 == 48	10/3/25 1:25 == 48.2	10/3/25 5:55 == 34.1

Pumpback Station Discharge (0364)

10/3/25 6:00 == 34	10/3/25 10:30 == 48.1	10/3/25 15:00 == 47.9	10/3/25 19:30 == 48
10/3/25 6:05 == 34.2	10/3/25 10:35 == 48.1	10/3/25 15:05 == 47.8	10/3/25 19:35 == 48.1
10/3/25 6:10 == 34.4	10/3/25 10:40 == 47.4	10/3/25 15:10 == 47.7	10/3/25 19:40 == 48.1
10/3/25 6:15 == 41.4	10/3/25 10:45 == 47.9	10/3/25 15:15 == 47.9	10/3/25 19:45 == 41.1
10/3/25 6:20 == 47	10/3/25 10:50 == 48.1	10/3/25 15:20 == 48.1	10/3/25 19:50 == 35.5
10/3/25 6:25 == 48	10/3/25 10:55 == 47.4	10/3/25 15:25 == 48.1	10/3/25 19:55 == 34.3
10/3/25 6:30 == 48	10/3/25 11:00 == 40.4	10/3/25 15:30 == 48.1	10/3/25 20:00 == 34.3
10/3/25 6:35 == 47.9	10/3/25 11:05 == 35.3	10/3/25 15:35 == 47.9	10/3/25 20:05 == 34.5
10/3/25 6:40 == 47.9	10/3/25 11:10 == 35.2	10/3/25 15:40 == 47.9	10/3/25 20:10 == 34.7
10/3/25 6:45 == 48	10/3/25 11:15 == 35	10/3/25 15:45 == 47.9	10/3/25 20:15 == 39.4
10/3/25 6:50 == 48.1	10/3/25 11:20 == 35	10/3/25 15:50 == 48	10/3/25 20:20 == 46.6
10/3/25 6:55 == 47.7	10/3/25 11:25 == 34.9	10/3/25 15:55 == 48.2	10/3/25 20:25 == 48
10/3/25 7:00 == 47.7	10/3/25 11:30 == 41.3	10/3/25 16:00 == 47.7	10/3/25 20:30 == 47.8
10/3/25 7:05 == 48	10/3/25 11:35 == 46.8	10/3/25 16:05 == 47.9	10/3/25 20:35 == 47.8
10/3/25 7:10 == 48	10/3/25 11:40 == 47.8	10/3/25 16:10 == 47.8	10/3/25 20:40 == 48
10/3/25 7:15 == 47.9	10/3/25 11:45 == 48	10/3/25 16:15 == 48.1	10/3/25 20:45 == 48
10/3/25 7:20 == 48	10/3/25 11:50 == 48	10/3/25 16:20 == 47.8	10/3/25 20:50 == 48
10/3/25 7:25 == 48	10/3/25 11:55 == 47.6	10/3/25 16:25 == 47.9	10/3/25 20:55 == 48
10/3/25 7:30 == 47.9	10/3/25 12:00 == 47.7	10/3/25 16:30 == 48.1	10/3/25 21:00 == 48
10/3/25 7:35 == 48.1	10/3/25 12:05 == 47.8	10/3/25 16:35 == 48	10/3/25 21:05 == 48
10/3/25 7:40 == 46.7	10/3/25 12:10 == 47.5	10/3/25 16:40 == 47.9	10/3/25 21:10 == 48
10/3/25 7:45 == 40.6	10/3/25 12:15 == 47.7	10/3/25 16:45 == 40.2	10/3/25 21:15 == 48.1
10/3/25 7:50 == 33.8	10/3/25 12:20 == 48.2	10/3/25 16:50 == 35	10/3/25 21:20 == 48
10/3/25 7:55 == 34	10/3/25 12:25 == 48.2	10/3/25 16:55 == 34.1	10/3/25 21:25 == 48
10/3/25 8:00 == 33.9	10/3/25 12:30 == 48.1	10/3/25 17:00 == 34.1	10/3/25 21:30 == 48.1
10/3/25 8:05 == 33.8	10/3/25 12:35 == 48.1	10/3/25 17:05 == 34.3	10/3/25 21:35 == 48
10/3/25 8:10 == 33.9	10/3/25 12:40 == 48	10/3/25 17:10 == 34.2	10/3/25 21:40 == 47.5
10/3/25 8:15 == 34.1	10/3/25 12:45 == 48	10/3/25 17:15 == 40	10/3/25 21:45 == 47.9
10/3/25 8:20 == 34.1	10/3/25 12:50 == 48.1	10/3/25 17:20 == 46.3	10/3/25 21:50 == 47.9
10/3/25 8:25 == 34.1	10/3/25 12:55 == 47.8	10/3/25 17:25 == 47.6	10/3/25 21:55 == 48
10/3/25 8:30 == 40.6	10/3/25 13:00 == 47.9	10/3/25 17:30 == 47.6	10/3/25 22:00 == 48
10/3/25 8:35 == 47	10/3/25 13:05 == 47.9	10/3/25 17:35 == 48	10/3/25 22:05 == 47.9
10/3/25 8:40 == 47.9	10/3/25 13:10 == 48	10/3/25 17:40 == 48	10/3/25 22:10 == 48
10/3/25 8:45 == 48.1	10/3/25 13:15 == 48	10/3/25 17:45 == 48	10/3/25 22:15 == 47.9
10/3/25 8:50 == 47.9	10/3/25 13:20 == 48.1	10/3/25 17:50 == 47.9	10/3/25 22:20 == 47.9
10/3/25 8:55 == 48	10/3/25 13:25 == 48	10/3/25 17:55 == 47.9	10/3/25 22:25 == 47.9
10/3/25 9:00 == 48	10/3/25 13:30 == 48	10/3/25 18:00 == 48	10/3/25 22:30 == 40.8
10/3/25 9:05 == 48	10/3/25 13:35 == 47.9	10/3/25 18:05 == 47.9	10/3/25 22:35 == 34.4
10/3/25 9:10 == 47.9	10/3/25 13:40 == 48	10/3/25 18:10 == 47.9	10/3/25 22:40 == 33.7
10/3/25 9:15 == 48	10/3/25 13:45 == 40.1	10/3/25 18:15 == 48	10/3/25 22:45 == 33.7
10/3/25 9:20 == 48.1	10/3/25 13:50 == 34.7	10/3/25 18:20 == 48.1	10/3/25 22:50 == 33.9
10/3/25 9:25 == 48	10/3/25 13:55 == 34.2	10/3/25 18:25 == 48	10/3/25 22:55 == 34
10/3/25 9:30 == 48.1	10/3/25 14:00 == 34.4	10/3/25 18:30 == 47.9	10/3/25 23:00 == 38.4
10/3/25 9:35 == 48	10/3/25 14:05 == 34.3	10/3/25 18:35 == 47.9	10/3/25 23:05 == 46.9
10/3/25 9:40 == 47.9	10/3/25 14:10 == 34.6	10/3/25 18:40 == 47.9	10/3/25 23:10 == 48.1
10/3/25 9:45 == 47.9	10/3/25 14:15 == 34.7	10/3/25 18:45 == 48	10/3/25 23:15 == 48
10/3/25 9:50 == 48	10/3/25 14:20 == 34.7	10/3/25 18:50 == 47.8	10/3/25 23:20 == 47.9
10/3/25 9:55 == 48	10/3/25 14:25 == 34.7	10/3/25 18:55 == 48	10/3/25 23:25 == 48
10/3/25 10:00 == 47.9	10/3/25 14:30 == 40.8	10/3/25 19:00 == 48.2	10/3/25 23:30 == 47.9
10/3/25 10:05 == 48	10/3/25 14:35 == 46.4	10/3/25 19:05 == 48.1	10/3/25 23:35 == 47.9
10/3/25 10:10 == 48	10/3/25 14:40 == 47.9	10/3/25 19:10 == 48.1	10/3/25 23:40 == 48
10/3/25 10:15 == 47.9	10/3/25 14:45 == 48	10/3/25 19:15 == 48	10/3/25 23:45 == 48
10/3/25 10:20 == 48	10/3/25 14:50 == 48	10/3/25 19:20 == 48	10/3/25 23:50 == 48
10/3/25 10:25 == 47.8	10/3/25 14:55 == 47.9	10/3/25 19:25 == 48	10/3/25 23:55 == 47.9

Pumpback Station Discharge (0364)

10/4/25 0:00 == 47.9	10/4/25 4:30 == 48	10/4/25 9:00 == 47.7	10/4/25 13:30 == 48
10/4/25 0:05 == 48	10/4/25 4:35 == 47.9	10/4/25 9:05 == 48	10/4/25 13:35 == 48
10/4/25 0:10 == 47.4	10/4/25 4:40 == 47.9	10/4/25 9:10 == 48	10/4/25 13:40 == 47.8
10/4/25 0:15 == 47.8	10/4/25 4:45 == 48	10/4/25 9:15 == 43.1	10/4/25 13:45 == 48
10/4/25 0:20 == 47.8	10/4/25 4:50 == 48	10/4/25 9:20 == 35	10/4/25 13:50 == 47.9
10/4/25 0:25 == 48	10/4/25 4:55 == 48	10/4/25 9:25 == 34	10/4/25 13:55 == 47.8
10/4/25 0:30 == 47.9	10/4/25 5:00 == 48.1	10/4/25 9:30 == 33.9	10/4/25 14:00 == 48
10/4/25 0:35 == 47.9	10/4/25 5:05 == 47.9	10/4/25 9:35 == 33.8	10/4/25 14:05 == 48.2
10/4/25 0:40 == 47.9	10/4/25 5:10 == 47.3	10/4/25 9:40 == 33.8	10/4/25 14:10 == 48.2
10/4/25 0:45 == 47.9	10/4/25 5:15 == 47.9	10/4/25 9:45 == 36.2	10/4/25 14:15 == 48
10/4/25 0:50 == 48.1	10/4/25 5:20 == 47.9	10/4/25 9:50 == 46.1	10/4/25 14:20 == 47.9
10/4/25 0:55 == 48	10/4/25 5:25 == 47.7	10/4/25 9:55 == 47.8	10/4/25 14:25 == 48
10/4/25 1:00 == 47.9	10/4/25 5:30 == 48	10/4/25 10:00 == 47.9	10/4/25 14:30 == 48.2
10/4/25 1:05 == 47.9	10/4/25 5:35 == 48.1	10/4/25 10:05 == 48.1	10/4/25 14:35 == 48.1
10/4/25 1:10 == 48	10/4/25 5:40 == 47.9	10/4/25 10:10 == 48.1	10/4/25 14:40 == 48
10/4/25 1:15 == 41.9	10/4/25 5:45 == 47.9	10/4/25 10:15 == 48	10/4/25 14:45 == 44.5
10/4/25 1:20 == 34.9	10/4/25 5:50 == 48	10/4/25 10:20 == 48.1	10/4/25 14:50 == 34.8
10/4/25 1:25 == 34.2	10/4/25 5:55 == 47.8	10/4/25 10:25 == 48	10/4/25 14:55 == 34.5
10/4/25 1:30 == 34.2	10/4/25 6:00 == 47.8	10/4/25 10:30 == 48.3	10/4/25 15:00 == 34.5
10/4/25 1:35 == 34.4	10/4/25 6:05 == 48	10/4/25 10:35 == 48.2	10/4/25 15:05 == 34.6
10/4/25 1:40 == 34.5	10/4/25 6:10 == 47.6	10/4/25 10:40 == 47.7	10/4/25 15:10 == 34.8
10/4/25 1:45 == 37.8	10/4/25 6:15 == 41.7	10/4/25 10:45 == 48	10/4/25 15:15 == 35
10/4/25 1:50 == 46.8	10/4/25 6:20 == 35.8	10/4/25 10:50 == 48	10/4/25 15:20 == 34.8
10/4/25 1:55 == 47.8	10/4/25 6:25 == 34.4	10/4/25 10:55 == 47.7	10/4/25 15:25 == 35.1
10/4/25 2:00 == 48.1	10/4/25 6:30 == 34.5	10/4/25 11:00 == 47.9	10/4/25 15:30 == 35.5
10/4/25 2:05 == 47.9	10/4/25 6:35 == 34.6	10/4/25 11:05 == 47.9	10/4/25 15:35 == 47.3
10/4/25 2:10 == 47.8	10/4/25 6:40 == 34.5	10/4/25 11:10 == 47.9	10/4/25 15:40 == 47.9
10/4/25 2:15 == 48.1	10/4/25 6:45 == 34.3	10/4/25 11:15 == 47.9	10/4/25 15:45 == 48.1
10/4/25 2:20 == 48.1	10/4/25 6:50 == 34.3	10/4/25 11:20 == 48	10/4/25 15:50 == 48
10/4/25 2:25 == 47.5	10/4/25 6:55 == 34.2	10/4/25 11:25 == 48	10/4/25 15:55 == 47.9
10/4/25 2:30 == 47.8	10/4/25 7:00 == 37.2	10/4/25 11:30 == 48.1	10/4/25 16:00 == 47.8
10/4/25 2:35 == 48	10/4/25 7:05 == 46.8	10/4/25 11:35 == 48.1	10/4/25 16:05 == 47.9
10/4/25 2:40 == 48.1	10/4/25 7:10 == 48.2	10/4/25 11:40 == 48	10/4/25 16:10 == 47.9
10/4/25 2:45 == 48.1	10/4/25 7:15 == 48	10/4/25 11:45 == 48	10/4/25 16:15 == 47.9
10/4/25 2:50 == 47.8	10/4/25 7:20 == 47.9	10/4/25 11:50 == 48	10/4/25 16:20 == 48.1
10/4/25 2:55 == 47.9	10/4/25 7:25 == 47.8	10/4/25 11:55 == 47.9	10/4/25 16:25 == 48
10/4/25 3:00 == 48	10/4/25 7:30 == 48	10/4/25 12:00 == 43.9	10/4/25 16:30 == 47.9
10/4/25 3:05 == 48.1	10/4/25 7:35 == 47.9	10/4/25 12:05 == 34.9	10/4/25 16:35 == 48
10/4/25 3:10 == 47.9	10/4/25 7:40 == 48.1	10/4/25 12:10 == 33.9	10/4/25 16:40 == 48.1
10/4/25 3:15 == 47.9	10/4/25 7:45 == 48	10/4/25 12:15 == 33.9	10/4/25 16:45 == 48.1
10/4/25 3:20 == 48.1	10/4/25 7:50 == 47.9	10/4/25 12:20 == 33.9	10/4/25 16:50 == 48
10/4/25 3:25 == 47.9	10/4/25 7:55 == 47.9	10/4/25 12:25 == 34	10/4/25 16:55 == 47.9
10/4/25 3:30 == 47.8	10/4/25 8:00 == 47.6	10/4/25 12:30 == 35.4	10/4/25 17:00 == 48
10/4/25 3:35 == 47.9	10/4/25 8:05 == 47.8	10/4/25 12:35 == 46.4	10/4/25 17:05 == 48
10/4/25 3:40 == 48	10/4/25 8:10 == 47.9	10/4/25 12:40 == 48.1	10/4/25 17:10 == 48.1
10/4/25 3:45 == 42.2	10/4/25 8:15 == 48	10/4/25 12:45 == 48.2	10/4/25 17:15 == 48
10/4/25 3:50 == 35.6	10/4/25 8:20 == 48	10/4/25 12:50 == 48	10/4/25 17:20 == 47.8
10/4/25 3:55 == 34.3	10/4/25 8:25 == 47.9	10/4/25 12:55 == 48	10/4/25 17:25 == 47.7
10/4/25 4:00 == 34.2	10/4/25 8:30 == 48	10/4/25 13:00 == 48	10/4/25 17:30 == 47.7
10/4/25 4:05 == 34.2	10/4/25 8:35 == 47.9	10/4/25 13:05 == 48	10/4/25 17:35 == 48
10/4/25 4:10 == 34.3	10/4/25 8:40 == 47.9	10/4/25 13:10 == 48	10/4/25 17:40 == 47.9
10/4/25 4:15 == 37.9	10/4/25 8:45 == 48	10/4/25 13:15 == 48.1	10/4/25 17:45 == 45.3
10/4/25 4:20 == 46.1	10/4/25 8:50 == 48	10/4/25 13:20 == 47.9	10/4/25 17:50 == 35.1
10/4/25 4:25 == 47.9	10/4/25 8:55 == 47.7	10/4/25 13:25 == 47.9	10/4/25 17:55 == 34.8

Pumpback Station Discharge (0364)

10/4/25 18:00 == 34.8	10/4/25 22:30 == 48	10/5/25 3:00 == 48.1	10/5/25 7:30 == 47.8
10/4/25 18:05 == 34.8	10/4/25 22:35 == 47.9	10/5/25 3:05 == 48	10/5/25 7:35 == 48
10/4/25 18:10 == 34.5	10/4/25 22:40 == 48	10/5/25 3:10 == 48	10/5/25 7:40 == 48.1
10/4/25 18:15 == 34.3	10/4/25 22:45 == 48	10/5/25 3:15 == 44.3	10/5/25 7:45 == 48
10/4/25 18:20 == 34.3	10/4/25 22:50 == 47.9	10/5/25 3:20 == 37.3	10/5/25 7:50 == 48.1
10/4/25 18:25 == 34.3	10/4/25 22:55 == 48.1	10/5/25 3:25 == 34.3	10/5/25 7:55 == 48.1
10/4/25 18:30 == 36.5	10/4/25 23:00 == 47.9	10/5/25 3:30 == 34.2	10/5/25 8:00 == 48
10/4/25 18:35 == 46.1	10/4/25 23:05 == 48	10/5/25 3:35 == 34.1	10/5/25 8:05 == 47.9
10/4/25 18:40 == 48	10/4/25 23:10 == 47.8	10/5/25 3:40 == 34	10/5/25 8:10 == 48
10/4/25 18:45 == 48	10/4/25 23:15 == 48	10/5/25 3:45 == 35.8	10/5/25 8:15 == 44.6
10/4/25 18:50 == 48.1	10/4/25 23:20 == 48	10/5/25 3:50 == 42.9	10/5/25 8:20 == 37.7
10/4/25 18:55 == 48	10/4/25 23:25 == 47.8	10/5/25 3:55 == 47.7	10/5/25 8:25 == 33.8
10/4/25 19:00 == 47.9	10/4/25 23:30 == 47.9	10/5/25 4:00 == 48.1	10/5/25 8:30 == 33.8
10/4/25 19:05 == 48	10/4/25 23:35 == 48.1	10/5/25 4:05 == 47.9	10/5/25 8:35 == 33.9
10/4/25 19:10 == 48	10/4/25 23:40 == 48.1	10/5/25 4:10 == 47.9	10/5/25 8:40 == 33.9
10/4/25 19:15 == 48.1	10/4/25 23:45 == 47.8	10/5/25 4:15 == 48	10/5/25 8:45 == 33.9
10/4/25 19:20 == 48	10/4/25 23:50 == 47.6	10/5/25 4:20 == 47.9	10/5/25 8:50 == 33.9
10/4/25 19:25 == 47.9	10/4/25 23:55 == 47.9	10/5/25 4:25 == 48	10/5/25 8:55 == 33.9
10/4/25 19:30 == 48	10/5/25 0:00 == 48	10/5/25 4:30 == 48	10/5/25 9:00 == 35.6
10/4/25 19:35 == 48	10/5/25 0:05 == 48	10/5/25 4:35 == 48	10/5/25 9:05 == 43.3
10/4/25 19:40 == 48	10/5/25 0:10 == 47.5	10/5/25 4:40 == 48.1	10/5/25 9:10 == 48.1
10/4/25 19:45 == 48	10/5/25 0:15 == 47.6	10/5/25 4:45 == 48	10/5/25 9:15 == 48
10/4/25 19:50 == 48	10/5/25 0:20 == 47.9	10/5/25 4:50 == 47.9	10/5/25 9:20 == 48.1
10/4/25 19:55 == 48.1	10/5/25 0:25 == 48	10/5/25 4:55 == 48	10/5/25 9:25 == 48.1
10/4/25 20:00 == 48.1	10/5/25 0:30 == 48	10/5/25 5:00 == 48	10/5/25 9:30 == 48
10/4/25 20:05 == 47.8	10/5/25 0:35 == 48	10/5/25 5:05 == 48.2	10/5/25 9:35 == 47.9
10/4/25 20:10 == 47.1	10/5/25 0:40 == 48	10/5/25 5:10 == 48.1	10/5/25 9:40 == 48
10/4/25 20:15 == 47.9	10/5/25 0:45 == 44.3	10/5/25 5:15 == 48	10/5/25 9:45 == 47.9
10/4/25 20:20 == 47.9	10/5/25 0:50 == 37.3	10/5/25 5:20 == 48	10/5/25 9:50 == 47.8
10/4/25 20:25 == 48	10/5/25 0:55 == 34.6	10/5/25 5:25 == 47.9	10/5/25 9:55 == 48.1
10/4/25 20:30 == 48.1	10/5/25 1:00 == 34.4	10/5/25 5:30 == 47.9	10/5/25 10:00 == 47.8
10/4/25 20:35 == 47.8	10/5/25 1:05 == 34.3	10/5/25 5:35 == 48.1	10/5/25 10:05 == 47.9
10/4/25 20:40 == 48	10/5/25 1:10 == 34.4	10/5/25 5:40 == 48	10/5/25 10:10 == 48
10/4/25 20:45 == 47.7	10/5/25 1:15 == 36.4	10/5/25 5:45 == 44.1	10/5/25 10:15 == 48
10/4/25 20:50 == 48	10/5/25 1:20 == 44.7	10/5/25 5:50 == 37.2	10/5/25 10:20 == 48.1
10/4/25 20:55 == 47.9	10/5/25 1:25 == 48.1	10/5/25 5:55 == 33.7	10/5/25 10:25 == 48.1
10/4/25 21:00 == 48.1	10/5/25 1:30 == 48	10/5/25 6:00 == 33.7	10/5/25 10:30 == 47.9
10/4/25 21:05 == 48	10/5/25 1:35 == 47.9	10/5/25 6:05 == 33.8	10/5/25 10:35 == 48
10/4/25 21:10 == 47.9	10/5/25 1:40 == 48	10/5/25 6:10 == 33.9	10/5/25 10:40 == 47.9
10/4/25 21:15 == 47.9	10/5/25 1:45 == 48	10/5/25 6:15 == 36.1	10/5/25 10:45 == 47.8
10/4/25 21:20 == 48	10/5/25 1:50 == 48.1	10/5/25 6:20 == 43.5	10/5/25 10:50 == 47.8
10/4/25 21:25 == 48	10/5/25 1:55 == 47.9	10/5/25 6:25 == 47.8	10/5/25 10:55 == 47.7
10/4/25 21:30 == 43.7	10/5/25 2:00 == 47.9	10/5/25 6:30 == 48	10/5/25 11:00 == 44.9
10/4/25 21:35 == 37.1	10/5/25 2:05 == 48.1	10/5/25 6:35 == 48.1	10/5/25 11:05 == 38.7
10/4/25 21:40 == 34.3	10/5/25 2:10 == 47.9	10/5/25 6:40 == 48	10/5/25 11:10 == 34.8
10/4/25 21:45 == 34.3	10/5/25 2:15 == 47.9	10/5/25 6:45 == 48	10/5/25 11:15 == 34.6
10/4/25 21:50 == 34.3	10/5/25 2:20 == 48	10/5/25 6:50 == 47.9	10/5/25 11:20 == 34.5
10/4/25 21:55 == 34.2	10/5/25 2:25 == 47.6	10/5/25 6:55 == 47.5	10/5/25 11:25 == 34.3
10/4/25 22:00 == 34.2	10/5/25 2:30 == 47.8	10/5/25 7:00 == 48	10/5/25 11:30 == 35.8
10/4/25 22:05 == 34.3	10/5/25 2:35 == 47.9	10/5/25 7:05 == 47.9	10/5/25 11:35 == 42.5
10/4/25 22:10 == 34.4	10/5/25 2:40 == 47.9	10/5/25 7:10 == 47.7	10/5/25 11:40 == 47.5
10/4/25 22:15 == 37.4	10/5/25 2:45 == 47.9	10/5/25 7:15 == 47.9	10/5/25 11:45 == 47.9
10/4/25 22:20 == 44.4	10/5/25 2:50 == 48.1	10/5/25 7:20 == 47.9	10/5/25 11:50 == 47.9
10/4/25 22:25 == 48	10/5/25 2:55 == 48.1	10/5/25 7:25 == 47.9	10/5/25 11:55 == 47.9

Pumpback Station Discharge (0364)

10/5/25 12:00 == 48.1	10/5/25 16:30 == 47.9	10/5/25 21:00 == 47.8	10/6/25 1:30 == 48
10/5/25 12:05 == 48	10/5/25 16:35 == 47.9	10/5/25 21:05 == 47.9	10/6/25 1:35 == 48.1
10/5/25 12:10 == 47.5	10/5/25 16:40 == 48	10/5/25 21:10 == 48	10/6/25 1:40 == 48.1
10/5/25 12:15 == 47.8	10/5/25 16:45 == 46.1	10/5/25 21:15 == 48	10/6/25 1:45 == 47.3
10/5/25 12:20 == 48.1	10/5/25 16:50 == 37.7	10/5/25 21:20 == 47.9	10/6/25 1:50 == 38.3
10/5/25 12:25 == 48.1	10/5/25 16:55 == 34	10/5/25 21:25 == 48	10/6/25 1:55 == 34.2
10/5/25 12:30 == 48	10/5/25 17:00 == 34	10/5/25 21:30 == 48.1	10/6/25 2:00 == 34.1
10/5/25 12:35 == 48.1	10/5/25 17:05 == 33.8	10/5/25 21:35 == 48.1	10/6/25 2:05 == 34.2
10/5/25 12:40 == 48.1	10/5/25 17:10 == 34	10/5/25 21:40 == 48.1	10/6/25 2:10 == 34
10/5/25 12:45 == 48	10/5/25 17:15 == 33.9	10/5/25 21:45 == 48	10/6/25 2:15 == 34.2
10/5/25 12:50 == 48.1	10/5/25 17:20 == 43.4	10/5/25 21:50 == 47.9	10/6/25 2:20 == 41.1
10/5/25 12:55 == 48.1	10/5/25 17:25 == 47.9	10/5/25 21:55 == 48.1	10/6/25 2:25 == 47.8
10/5/25 13:00 == 48.1	10/5/25 17:30 == 48	10/5/25 22:00 == 48	10/6/25 2:30 == 48
10/5/25 13:05 == 48.1	10/5/25 17:35 == 47.9	10/5/25 22:05 == 48	10/6/25 2:35 == 48
10/5/25 13:10 == 47.9	10/5/25 17:40 == 48	10/5/25 22:10 == 47.7	10/6/25 2:40 == 48
10/5/25 13:15 == 47.9	10/5/25 17:45 == 47.8	10/5/25 22:15 == 47.8	10/6/25 2:45 == 48
10/5/25 13:20 == 47.9	10/5/25 17:50 == 47.9	10/5/25 22:20 == 47.9	10/6/25 2:50 == 48
10/5/25 13:25 == 47.9	10/5/25 17:55 == 47.8	10/5/25 22:25 == 48	10/6/25 2:55 == 48
10/5/25 13:30 == 47.8	10/5/25 18:00 == 47.8	10/5/25 22:30 == 48	10/6/25 3:00 == 48.1
10/5/25 13:35 == 47.9	10/5/25 18:05 == 47.9	10/5/25 22:35 == 47.9	10/6/25 3:05 == 48.1
10/5/25 13:40 == 48	10/5/25 18:10 == 48	10/5/25 22:40 == 47.9	10/6/25 3:10 == 48
10/5/25 13:45 == 48	10/5/25 18:15 == 48	10/5/25 22:45 == 48.1	10/6/25 3:15 == 47.9
10/5/25 13:50 == 48	10/5/25 18:20 == 48	10/5/25 22:50 == 37	10/6/25 3:20 == 48
10/5/25 13:55 == 47.9	10/5/25 18:25 == 48	10/5/25 22:55 == 34.5	10/6/25 3:25 == 47.4
10/5/25 14:00 == 45.5	10/5/25 18:30 == 48	10/5/25 23:00 == 34.4	10/6/25 3:30 == 48.1
10/5/25 14:05 == 37.5	10/5/25 18:35 == 48	10/5/25 23:05 == 34.5	10/6/25 3:35 == 48.1
10/5/25 14:10 == 34	10/5/25 18:40 == 48	10/5/25 23:10 == 34.3	10/6/25 3:40 == 47.8
10/5/25 14:15 == 34.3	10/5/25 18:45 == 48	10/5/25 23:15 == 34.4	10/6/25 3:45 == 48
10/5/25 14:20 == 34.3	10/5/25 18:50 == 48.1	10/5/25 23:20 == 42.5	10/6/25 3:50 == 48.1
10/5/25 14:25 == 34.5	10/5/25 18:55 == 48.1	10/5/25 23:25 == 47.4	10/6/25 3:55 == 47.9
10/5/25 14:30 == 35.1	10/5/25 19:00 == 48	10/5/25 23:30 == 48.1	10/6/25 4:00 == 48
10/5/25 14:35 == 43.5	10/5/25 19:05 == 47.9	10/5/25 23:35 == 48.1	10/6/25 4:05 == 48.1
10/5/25 14:40 == 47.9	10/5/25 19:10 == 47.7	10/5/25 23:40 == 48	10/6/25 4:10 == 48.1
10/5/25 14:45 == 47.9	10/5/25 19:15 == 46.1	10/5/25 23:45 == 48	10/6/25 4:15 == 48.1
10/5/25 14:50 == 47.9	10/5/25 19:20 == 38.6	10/5/25 23:50 == 48	10/6/25 4:20 == 48
10/5/25 14:55 == 48	10/5/25 19:25 == 34	10/5/25 23:55 == 47.7	10/6/25 4:25 == 48.1
10/5/25 15:00 == 48.1	10/5/25 19:30 == 34.1	10/6/25 0:00 == 47.5	10/6/25 4:30 == 48.1
10/5/25 15:05 == 48	10/5/25 19:35 == 34	10/6/25 0:05 == 47.7	10/6/25 4:35 == 48
10/5/25 15:10 == 47.5	10/5/25 19:40 == 34	10/6/25 0:10 == 47.7	10/6/25 4:40 == 48
10/5/25 15:15 == 48	10/5/25 19:45 == 34.3	10/6/25 0:15 == 47.9	10/6/25 4:45 == 48
10/5/25 15:20 == 48	10/5/25 19:50 == 42.1	10/6/25 0:20 == 48	10/6/25 4:50 == 47.9
10/5/25 15:25 == 47.9	10/5/25 19:55 == 47.8	10/6/25 0:25 == 48.1	10/6/25 4:55 == 48
10/5/25 15:30 == 47.9	10/5/25 20:00 == 48	10/6/25 0:30 == 48.2	10/6/25 5:00 == 48
10/5/25 15:35 == 48	10/5/25 20:05 == 48.1	10/6/25 0:35 == 48.1	10/6/25 5:05 == 47.9
10/5/25 15:40 == 48	10/5/25 20:10 == 47.6	10/6/25 0:40 == 48.2	10/6/25 5:10 == 47.7
10/5/25 15:45 == 47.9	10/5/25 20:15 == 47.9	10/6/25 0:45 == 48	10/6/25 5:15 == 47.8
10/5/25 15:50 == 48	10/5/25 20:20 == 47.9	10/6/25 0:50 == 48	10/6/25 5:20 == 48
10/5/25 15:55 == 47.8	10/5/25 20:25 == 48	10/6/25 0:55 == 48	10/6/25 5:25 == 48
10/5/25 16:00 == 47.8	10/5/25 20:30 == 48	10/6/25 1:00 == 47.9	10/6/25 5:30 == 48
10/5/25 16:05 == 48	10/5/25 20:35 == 48	10/6/25 1:05 == 48.1	10/6/25 5:35 == 47.9
10/5/25 16:10 == 48	10/5/25 20:40 == 48.1	10/6/25 1:10 == 48	10/6/25 5:40 == 47.7
10/5/25 16:15 == 48	10/5/25 20:45 == 48	10/6/25 1:15 == 48	10/6/25 5:45 == 47.8
10/5/25 16:20 == 48	10/5/25 20:50 == 48.1	10/6/25 1:20 == 47.6	10/6/25 5:50 == 48
10/5/25 16:25 == 47.9	10/5/25 20:55 == 47.9	10/6/25 1:25 == 48	10/6/25 5:55 == 47.9

Pumpback Station Discharge (0364)

10/6/25 6:00 == 47.9	10/6/25 10:30 == 34.8	10/6/25 15:00 == 34.1	10/6/25 19:30 == 47.8
10/6/25 6:05 == 47.9	10/6/25 10:35 == 39.4	10/6/25 15:05 == 40.2	10/6/25 19:35 == 48
10/6/25 6:10 == 47.5	10/6/25 10:40 == 47.8	10/6/25 15:10 == 46.5	10/6/25 19:40 == 47.9
10/6/25 6:15 == 48	10/6/25 10:45 == 48	10/6/25 15:15 == 48	10/6/25 19:45 == 47.9
10/6/25 6:20 == 48.2	10/6/25 10:50 == 47.9	10/6/25 15:20 == 48.2	10/6/25 19:50 == 48.1
10/6/25 6:25 == 48.2	10/6/25 10:55 == 47.5	10/6/25 15:25 == 48.1	10/6/25 19:55 == 48.1
10/6/25 6:30 == 48.2	10/6/25 11:00 == 47.7	10/6/25 15:30 == 48	10/6/25 20:00 == 48.2
10/6/25 6:35 == 47.8	10/6/25 11:05 == 48	10/6/25 15:35 == 47.8	10/6/25 20:05 == 48.2
10/6/25 6:40 == 48.1	10/6/25 11:10 == 47.9	10/6/25 15:40 == 47.8	10/6/25 20:10 == 47.6
10/6/25 6:45 == 48.1	10/6/25 11:15 == 48	10/6/25 15:45 == 47.9	10/6/25 20:15 == 47.7
10/6/25 6:50 == 38	10/6/25 11:20 == 48.1	10/6/25 15:50 == 47.7	10/6/25 20:20 == 48
10/6/25 6:55 == 34.2	10/6/25 11:25 == 47.8	10/6/25 15:55 == 47.5	10/6/25 20:25 == 48
10/6/25 7:00 == 33.7	10/6/25 11:30 == 47.9	10/6/25 16:00 == 48	10/6/25 20:30 == 48
10/6/25 7:05 == 33.9	10/6/25 11:35 == 48	10/6/25 16:05 == 48	10/6/25 20:35 == 48
10/6/25 7:10 == 34	10/6/25 11:40 == 47.9	10/6/25 16:10 == 47.9	10/6/25 20:40 == 47.8
10/6/25 7:15 == 34.1	10/6/25 11:45 == 48	10/6/25 16:15 == 48.1	10/6/25 20:45 == 47.8
10/6/25 7:20 == 41.3	10/6/25 11:50 == 48	10/6/25 16:20 == 47.9	10/6/25 20:50 == 47.9
10/6/25 7:25 == 47.4	10/6/25 11:55 == 47.7	10/6/25 16:25 == 48.1	10/6/25 20:55 == 47.9
10/6/25 7:30 == 47.8	10/6/25 12:00 == 47.5	10/6/25 16:30 == 48	10/6/25 21:00 == 47.9
10/6/25 7:35 == 47.6	10/6/25 12:05 == 47.9	10/6/25 16:35 == 48	10/6/25 21:05 == 47.9
10/6/25 7:40 == 47.7	10/6/25 12:10 == 47.4	10/6/25 16:40 == 48	10/6/25 21:10 == 47.9
10/6/25 7:45 == 48	10/6/25 12:15 == 47.7	10/6/25 16:45 == 47.7	10/6/25 21:15 == 47.9
10/6/25 7:50 == 48	10/6/25 12:20 == 48.1	10/6/25 16:50 == 48	10/6/25 21:20 == 48
10/6/25 7:55 == 47.9	10/6/25 12:25 == 48.1	10/6/25 16:55 == 47.9	10/6/25 21:25 == 48.1
10/6/25 8:00 == 47.8	10/6/25 12:30 == 48.1	10/6/25 17:00 == 48	10/6/25 21:30 == 48.1
10/6/25 8:05 == 47.6	10/6/25 12:35 == 48.1	10/6/25 17:05 == 48	10/6/25 21:35 == 47.9
10/6/25 8:10 == 47.7	10/6/25 12:40 == 48.1	10/6/25 17:10 == 47.6	10/6/25 21:40 == 48.1
10/6/25 8:15 == 47.8	10/6/25 12:45 == 48	10/6/25 17:15 == 47.9	10/6/25 21:45 == 48
10/6/25 8:20 == 47.9	10/6/25 12:50 == 47.9	10/6/25 17:20 == 48.1	10/6/25 21:50 == 48
10/6/25 8:25 == 48.1	10/6/25 12:55 == 47.9	10/6/25 17:25 == 47.6	10/6/25 21:55 == 47.9
10/6/25 8:30 == 48	10/6/25 13:00 == 48.1	10/6/25 17:30 == 47.7	10/6/25 22:00 == 48.1
10/6/25 8:35 == 48.1	10/6/25 13:05 == 48.1	10/6/25 17:35 == 48	10/6/25 22:05 == 48.2
10/6/25 8:40 == 47.9	10/6/25 13:10 == 48	10/6/25 17:40 == 48	10/6/25 22:10 == 47.6
10/6/25 8:45 == 48	10/6/25 13:15 == 47.9	10/6/25 17:45 == 47.9	10/6/25 22:15 == 47.8
10/6/25 8:50 == 48.1	10/6/25 13:20 == 47.6	10/6/25 17:50 == 47.9	10/6/25 22:20 == 47.9
10/6/25 8:55 == 48	10/6/25 13:25 == 48	10/6/25 17:55 == 47.9	10/6/25 22:25 == 47.5
10/6/25 9:00 == 47.9	10/6/25 13:30 == 47.9	10/6/25 18:00 == 47.2	10/6/25 22:30 == 47.8
10/6/25 9:05 == 48	10/6/25 13:35 == 47.9	10/6/25 18:05 == 41.4	10/6/25 22:35 == 48
10/6/25 9:10 == 48	10/6/25 13:40 == 47.9	10/6/25 18:10 == 34	10/6/25 22:40 == 47.6
10/6/25 9:15 == 48	10/6/25 13:45 == 48.1	10/6/25 18:15 == 33.5	10/6/25 22:45 == 47.7
10/6/25 9:20 == 48	10/6/25 13:50 == 47.9	10/6/25 18:20 == 33.5	10/6/25 22:50 == 48
10/6/25 9:25 == 48.1	10/6/25 13:55 == 48	10/6/25 18:25 == 33.6	10/6/25 22:55 == 48.1
10/6/25 9:30 == 48	10/6/25 14:00 == 48.1	10/6/25 18:30 == 33.8	10/6/25 23:00 == 48.1
10/6/25 9:35 == 47.9	10/6/25 14:05 == 48.1	10/6/25 18:35 == 37.5	10/6/25 23:05 == 48
10/6/25 9:40 == 47.9	10/6/25 14:10 == 47.8	10/6/25 18:40 == 47.5	10/6/25 23:10 == 48
10/6/25 9:45 == 47.9	10/6/25 14:15 == 47.9	10/6/25 18:45 == 48	10/6/25 23:15 == 48
10/6/25 9:50 == 48	10/6/25 14:20 == 48	10/6/25 18:50 == 47.8	10/6/25 23:20 == 47.9
10/6/25 9:55 == 47.9	10/6/25 14:25 == 47.9	10/6/25 18:55 == 47.5	10/6/25 23:25 == 47.9
10/6/25 10:00 == 46.9	10/6/25 14:30 == 47.9	10/6/25 19:00 == 47.9	10/6/25 23:30 == 47.9
10/6/25 10:05 == 39.9	10/6/25 14:35 == 39.6	10/6/25 19:05 == 48.1	10/6/25 23:35 == 48.2
10/6/25 10:10 == 33.7	10/6/25 14:40 == 35	10/6/25 19:10 == 48.2	10/6/25 23:40 == 48.1
10/6/25 10:15 == 33.7	10/6/25 14:45 == 34.3	10/6/25 19:15 == 48	10/6/25 23:45 == 47.9
10/6/25 10:20 == 33.8	10/6/25 14:50 == 34.2	10/6/25 19:20 == 48	10/6/25 23:50 == 47.9
10/6/25 10:25 == 34.1	10/6/25 14:55 == 34.2	10/6/25 19:25 == 47.9	10/6/25 23:55 == 48

Pumpback Station Discharge (0364)

10/7/25 0:00 == 48	10/7/25 4:30 == 47.9	10/7/25 9:00 == 47.9	10/7/25 13:30 == 48
10/7/25 0:05 == 47.9	10/7/25 4:35 == 48	10/7/25 9:05 == 41.8	10/7/25 13:35 == 48
10/7/25 0:10 == 47.3	10/7/25 4:40 == 47.9	10/7/25 9:10 == 35.4	10/7/25 13:40 == 48
10/7/25 0:15 == 48	10/7/25 4:45 == 48	10/7/25 9:15 == 33.6	10/7/25 13:45 == 48
10/7/25 0:20 == 48.1	10/7/25 4:50 == 48	10/7/25 9:20 == 33.6	10/7/25 13:50 == 47.9
10/7/25 0:25 == 48.1	10/7/25 4:55 == 47.8	10/7/25 9:25 == 33.7	10/7/25 13:55 == 47.5
10/7/25 0:30 == 48	10/7/25 5:00 == 48	10/7/25 9:30 == 33.6	10/7/25 14:00 == 47.7
10/7/25 0:35 == 48.1	10/7/25 5:05 == 48	10/7/25 9:35 == 37.6	10/7/25 14:05 == 47.9
10/7/25 0:40 == 48	10/7/25 5:10 == 47.9	10/7/25 9:40 == 45.2	10/7/25 14:10 == 47.7
10/7/25 0:45 == 47.9	10/7/25 5:15 == 47.8	10/7/25 9:45 == 47.9	10/7/25 14:15 == 47.8
10/7/25 0:50 == 48	10/7/25 5:20 == 48	10/7/25 9:50 == 47.9	10/7/25 14:20 == 47.9
10/7/25 0:55 == 48	10/7/25 5:25 == 48.1	10/7/25 9:55 == 47.4	10/7/25 14:25 == 47.6
10/7/25 1:00 == 48	10/7/25 5:30 == 48.2	10/7/25 10:00 == 47.5	10/7/25 14:30 == 47.7
10/7/25 1:05 == 48.1	10/7/25 5:35 == 47.8	10/7/25 10:05 == 48	10/7/25 14:35 == 48
10/7/25 1:10 == 47.6	10/7/25 5:40 == 48	10/7/25 10:10 == 48.1	10/7/25 14:40 == 48.1
10/7/25 1:15 == 47.6	10/7/25 5:45 == 48	10/7/25 10:15 == 48	10/7/25 14:45 == 47.9
10/7/25 1:20 == 47.9	10/7/25 5:50 == 47.8	10/7/25 10:20 == 48.1	10/7/25 14:50 == 48.1
10/7/25 1:25 == 48.1	10/7/25 5:55 == 47.8	10/7/25 10:25 == 48.1	10/7/25 14:55 == 48
10/7/25 1:30 == 47.9	10/7/25 6:00 == 47.9	10/7/25 10:30 == 48	10/7/25 15:00 == 47.9
10/7/25 1:35 == 48	10/7/25 6:05 == 47.9	10/7/25 10:35 == 47.9	10/7/25 15:05 == 48
10/7/25 1:40 == 48	10/7/25 6:10 == 47.3	10/7/25 10:40 == 47.6	10/7/25 15:10 == 48
10/7/25 1:45 == 47.9	10/7/25 6:15 == 47.8	10/7/25 10:45 == 47.9	10/7/25 15:15 == 47.8
10/7/25 1:50 == 48.1	10/7/25 6:20 == 48.1	10/7/25 10:50 == 48	10/7/25 15:20 == 48
10/7/25 1:55 == 48.2	10/7/25 6:25 == 48.2	10/7/25 10:55 == 47.7	10/7/25 15:25 == 47.8
10/7/25 2:00 == 48	10/7/25 6:30 == 48.1	10/7/25 11:00 == 47.8	10/7/25 15:30 == 48
10/7/25 2:05 == 48.1	10/7/25 6:35 == 48.1	10/7/25 11:05 == 47.7	10/7/25 15:35 == 47.9
10/7/25 2:10 == 48.1	10/7/25 6:40 == 48	10/7/25 11:10 == 48	10/7/25 15:40 == 48.1
10/7/25 2:15 == 47.4	10/7/25 6:45 == 47.9	10/7/25 11:15 == 48	10/7/25 15:45 == 47.9
10/7/25 2:20 == 43.3	10/7/25 6:50 == 47.9	10/7/25 11:20 == 48.1	10/7/25 15:50 == 48
10/7/25 2:25 == 34.2	10/7/25 6:55 == 47.9	10/7/25 11:25 == 47.8	10/7/25 15:55 == 47.5
10/7/25 2:30 == 34.2	10/7/25 7:00 == 47.9	10/7/25 11:30 == 48	10/7/25 16:00 == 47.9
10/7/25 2:35 == 34.2	10/7/25 7:05 == 47.8	10/7/25 11:35 == 48	10/7/25 16:05 == 48
10/7/25 2:40 == 34	10/7/25 7:10 == 47.7	10/7/25 11:40 == 47.9	10/7/25 16:10 == 47.9
10/7/25 2:45 == 34.4	10/7/25 7:15 == 47.9	10/7/25 11:45 == 47.9	10/7/25 16:15 == 48.1
10/7/25 2:50 == 36.9	10/7/25 7:20 == 48.1	10/7/25 11:50 == 48	10/7/25 16:20 == 48.1
10/7/25 2:55 == 47.8	10/7/25 7:25 == 47.8	10/7/25 11:55 == 47.5	10/7/25 16:25 == 48
10/7/25 3:00 == 47.9	10/7/25 7:30 == 47.8	10/7/25 12:00 == 47.6	10/7/25 16:30 == 48
10/7/25 3:05 == 48.1	10/7/25 7:35 == 48	10/7/25 12:05 == 47.9	10/7/25 16:35 == 48
10/7/25 3:10 == 48	10/7/25 7:40 == 48.1	10/7/25 12:10 == 47.9	10/7/25 16:40 == 48.1
10/7/25 3:15 == 48.1	10/7/25 7:45 == 47.9	10/7/25 12:15 == 48	10/7/25 16:45 == 48.1
10/7/25 3:20 == 48	10/7/25 7:50 == 47.8	10/7/25 12:20 == 48	10/7/25 16:50 == 48.1
10/7/25 3:25 == 47.5	10/7/25 7:55 == 47.5	10/7/25 12:25 == 47.9	10/7/25 16:55 == 48
10/7/25 3:30 == 47.9	10/7/25 8:00 == 47.4	10/7/25 12:30 == 47.9	10/7/25 17:00 == 48
10/7/25 3:35 == 48.1	10/7/25 8:05 == 48.1	10/7/25 12:35 == 48.1	10/7/25 17:05 == 48.2
10/7/25 3:40 == 47.6	10/7/25 8:10 == 47.9	10/7/25 12:40 == 48.2	10/7/25 17:10 == 48.1
10/7/25 3:45 == 47.9	10/7/25 8:15 == 47.9	10/7/25 12:45 == 48.3	10/7/25 17:15 == 47.9
10/7/25 3:50 == 48.1	10/7/25 8:20 == 48	10/7/25 12:50 == 47.9	10/7/25 17:20 == 48
10/7/25 3:55 == 48	10/7/25 8:25 == 48.1	10/7/25 12:55 == 48.1	10/7/25 17:25 == 47.8
10/7/25 4:00 == 48	10/7/25 8:30 == 48	10/7/25 13:00 == 48	10/7/25 17:30 == 47.8
10/7/25 4:05 == 48	10/7/25 8:35 == 48	10/7/25 13:05 == 48	10/7/25 17:35 == 47.8
10/7/25 4:10 == 48	10/7/25 8:40 == 48	10/7/25 13:10 == 47.9	10/7/25 17:40 == 47.6
10/7/25 4:15 == 48.1	10/7/25 8:45 == 47.9	10/7/25 13:15 == 48.1	10/7/25 17:45 == 47.8
10/7/25 4:20 == 48.2	10/7/25 8:50 == 48.1	10/7/25 13:20 == 47.9	10/7/25 17:50 == 47.9
10/7/25 4:25 == 48	10/7/25 8:55 == 48	10/7/25 13:25 == 48	10/7/25 17:55 == 47.9

Pumpback Station Discharge (0364)

10/7/25 18:00 == 48.3	10/7/25 22:30 == 47.9	10/8/25 3:00 == 48.1	10/8/25 7:30 == 47.8
10/7/25 18:05 == 48	10/7/25 22:35 == 47.8	10/8/25 3:05 == 48.1	10/8/25 7:35 == 48
10/7/25 18:10 == 47.9	10/7/25 22:40 == 47.5	10/8/25 3:10 == 48.2	10/8/25 7:40 == 48
10/7/25 18:15 == 48.1	10/7/25 22:45 == 47.8	10/8/25 3:15 == 48.2	10/8/25 7:45 == 48
10/7/25 18:20 == 48.1	10/7/25 22:50 == 48.1	10/8/25 3:20 == 48.1	10/8/25 7:50 == 48
10/7/25 18:25 == 48.1	10/7/25 22:55 == 48.1	10/8/25 3:25 == 47.5	10/8/25 7:55 == 47.9
10/7/25 18:30 == 47.7	10/7/25 23:00 == 48	10/8/25 3:30 == 47.4	10/8/25 8:00 == 48
10/7/25 18:35 == 44.3	10/7/25 23:05 == 48	10/8/25 3:35 == 47.8	10/8/25 8:05 == 48.1
10/7/25 18:40 == 34.8	10/7/25 23:10 == 48	10/8/25 3:40 == 47.8	10/8/25 8:10 == 48
10/7/25 18:45 == 33.8	10/7/25 23:15 == 47.9	10/8/25 3:45 == 47.9	10/8/25 8:15 == 48
10/7/25 18:50 == 33.8	10/7/25 23:20 == 48	10/8/25 3:50 == 47.9	10/8/25 8:20 == 48
10/7/25 18:55 == 33.9	10/7/25 23:25 == 47.8	10/8/25 3:55 == 47.9	10/8/25 8:25 == 47.9
10/7/25 19:00 == 33.8	10/7/25 23:30 == 48	10/8/25 4:00 == 47.9	10/8/25 8:30 == 48
10/7/25 19:05 == 36.9	10/7/25 23:35 == 47.9	10/8/25 4:05 == 48	10/8/25 8:35 == 47.7
10/7/25 19:10 == 44.8	10/7/25 23:40 == 48.2	10/8/25 4:10 == 48	10/8/25 8:40 == 47.7
10/7/25 19:15 == 47.9	10/7/25 23:45 == 48.1	10/8/25 4:15 == 48	10/8/25 8:45 == 48
10/7/25 19:20 == 48.1	10/7/25 23:50 == 48	10/8/25 4:20 == 48	10/8/25 8:50 == 48
10/7/25 19:25 == 48.1	10/7/25 23:55 == 48	10/8/25 4:25 == 48.1	10/8/25 8:55 == 48
10/7/25 19:30 == 48.1	10/8/25 0:00 == 48	10/8/25 4:30 == 47.9	10/8/25 9:00 == 48
10/7/25 19:35 == 48.2	10/8/25 0:05 == 48	10/8/25 4:35 == 48	10/8/25 9:05 == 48
10/7/25 19:40 == 48	10/8/25 0:10 == 47.5	10/8/25 4:40 == 48	10/8/25 9:10 == 47.8
10/7/25 19:45 == 47.8	10/8/25 0:15 == 47.8	10/8/25 4:45 == 47.9	10/8/25 9:15 == 47.9
10/7/25 19:50 == 47.9	10/8/25 0:20 == 47.9	10/8/25 4:50 == 48.1	10/8/25 9:20 == 48
10/7/25 19:55 == 47.9	10/8/25 0:25 == 47.9	10/8/25 4:55 == 48.1	10/8/25 9:25 == 47.9
10/7/25 20:00 == 48	10/8/25 0:30 == 47.9	10/8/25 5:00 == 48	10/8/25 9:30 == 48
10/7/25 20:05 == 48	10/8/25 0:35 == 48	10/8/25 5:05 == 48	10/8/25 9:35 == 48
10/7/25 20:10 == 47.8	10/8/25 0:40 == 47.9	10/8/25 5:10 == 47.6	10/8/25 9:40 == 48
10/7/25 20:15 == 48	10/8/25 0:45 == 47.9	10/8/25 5:15 == 47.9	10/8/25 9:45 == 47.9
10/7/25 20:20 == 48	10/8/25 0:50 == 48	10/8/25 5:20 == 48.1	10/8/25 9:50 == 48.1
10/7/25 20:25 == 48.1	10/8/25 0:55 == 48	10/8/25 5:25 == 48	10/8/25 9:55 == 47.8
10/7/25 20:30 == 48.2	10/8/25 1:00 == 47.9	10/8/25 5:30 == 47.9	10/8/25 10:00 == 48
10/7/25 20:35 == 48	10/8/25 1:05 == 48	10/8/25 5:35 == 47.9	10/8/25 10:05 == 48
10/7/25 20:40 == 47.5	10/8/25 1:10 == 48.1	10/8/25 5:40 == 47.8	10/8/25 10:10 == 47.5
10/7/25 20:45 == 48	10/8/25 1:15 == 48	10/8/25 5:45 == 47.9	10/8/25 10:15 == 47.6
10/7/25 20:50 == 48.1	10/8/25 1:20 == 48	10/8/25 5:50 == 48	10/8/25 10:20 == 48
10/7/25 20:55 == 47.6	10/8/25 1:25 == 48.1	10/8/25 5:55 == 47.9	10/8/25 10:25 == 48.1
10/7/25 21:00 == 47.8	10/8/25 1:30 == 48.1	10/8/25 6:00 == 48	10/8/25 10:30 == 47.8
10/7/25 21:05 == 48	10/8/25 1:35 == 48	10/8/25 6:05 == 48.1	10/8/25 10:35 == 47.6
10/7/25 21:10 == 48.1	10/8/25 1:40 == 48.1	10/8/25 6:10 == 48	10/8/25 10:40 == 47.8
10/7/25 21:15 == 48.1	10/8/25 1:45 == 48	10/8/25 6:15 == 48	10/8/25 10:45 == 47.9
10/7/25 21:20 == 48	10/8/25 1:50 == 47.9	10/8/25 6:20 == 48.1	10/8/25 10:50 == 47.9
10/7/25 21:25 == 48	10/8/25 1:55 == 48	10/8/25 6:25 == 48	10/8/25 10:55 == 47.6
10/7/25 21:30 == 48.1	10/8/25 2:00 == 48	10/8/25 6:30 == 48	10/8/25 11:00 == 47.7
10/7/25 21:35 == 47.9	10/8/25 2:05 == 47.9	10/8/25 6:35 == 48.1	10/8/25 11:05 == 48
10/7/25 21:40 == 47.9	10/8/25 2:10 == 48	10/8/25 6:40 == 48	10/8/25 11:10 == 48
10/7/25 21:45 == 48.1	10/8/25 2:15 == 48	10/8/25 6:45 == 48.1	10/8/25 11:15 == 48
10/7/25 21:50 == 48	10/8/25 2:20 == 48.1	10/8/25 6:50 == 46.3	10/8/25 11:20 == 48
10/7/25 21:55 == 47.9	10/8/25 2:25 == 47.7	10/8/25 6:55 == 35.6	10/8/25 11:25 == 48
10/7/25 22:00 == 48	10/8/25 2:30 == 47.9	10/8/25 7:00 == 34	10/8/25 11:30 == 48
10/7/25 22:05 == 48	10/8/25 2:35 == 47.8	10/8/25 7:05 == 33.7	10/8/25 11:35 == 47.9
10/7/25 22:10 == 47.7	10/8/25 2:40 == 48	10/8/25 7:10 == 34.1	10/8/25 11:40 == 48.1
10/7/25 22:15 == 47.8	10/8/25 2:45 == 47.9	10/8/25 7:15 == 33.9	10/8/25 11:45 == 48.1
10/7/25 22:20 == 47.9	10/8/25 2:50 == 48	10/8/25 7:20 == 33.6	10/8/25 11:50 == 48
10/7/25 22:25 == 47.9	10/8/25 2:55 == 48	10/8/25 7:25 == 44.5	10/8/25 11:55 == 47.9

Pumpback Station Discharge (0364)

10/8/25 12:00 == 48	10/8/25 16:30 == 33.8	10/8/25 21:00 == 47.9	10/9/25 1:30 == 48
10/8/25 12:05 == 48	10/8/25 16:35 == 35.6	10/8/25 21:05 == 48	10/9/25 1:35 == 47.5
10/8/25 12:10 == 47.8	10/8/25 16:40 == 42	10/8/25 21:10 == 48	10/9/25 1:40 == 47.9
10/8/25 12:15 == 48.1	10/8/25 16:45 == 48.1	10/8/25 21:15 == 48.1	10/9/25 1:45 == 48
10/8/25 12:20 == 47.9	10/8/25 16:50 == 48	10/8/25 21:20 == 48	10/9/25 1:50 == 47.8
10/8/25 12:25 == 48.1	10/8/25 16:55 == 48	10/8/25 21:25 == 48	10/9/25 1:55 == 47.8
10/8/25 12:30 == 47.9	10/8/25 17:00 == 48.1	10/8/25 21:30 == 48.1	10/9/25 2:00 == 48
10/8/25 12:35 == 48.2	10/8/25 17:05 == 48.1	10/8/25 21:35 == 48.1	10/9/25 2:05 == 48
10/8/25 12:40 == 48	10/8/25 17:10 == 48	10/8/25 21:40 == 48.2	10/9/25 2:10 == 47.8
10/8/25 12:45 == 48	10/8/25 17:15 == 48.2	10/8/25 21:45 == 48.2	10/9/25 2:15 == 47.9
10/8/25 12:50 == 47.9	10/8/25 17:20 == 47.9	10/8/25 21:50 == 48.1	10/9/25 2:20 == 48.1
10/8/25 12:55 == 47.9	10/8/25 17:25 == 47.6	10/8/25 21:55 == 48	10/9/25 2:25 == 47.5
10/8/25 13:00 == 48	10/8/25 17:30 == 47.9	10/8/25 22:00 == 47.8	10/9/25 2:30 == 47.6
10/8/25 13:05 == 48	10/8/25 17:35 == 47.9	10/8/25 22:05 == 47.9	10/9/25 2:35 == 48.1
10/8/25 13:10 == 48	10/8/25 17:40 == 48.1	10/8/25 22:10 == 47.9	10/9/25 2:40 == 47.9
10/8/25 13:15 == 48	10/8/25 17:45 == 48	10/8/25 22:15 == 48	10/9/25 2:45 == 47.9
10/8/25 13:20 == 48.1	10/8/25 17:50 == 48.1	10/8/25 22:20 == 47.9	10/9/25 2:50 == 48
10/8/25 13:25 == 48	10/8/25 17:55 == 47.8	10/8/25 22:25 == 48	10/9/25 2:55 == 48
10/8/25 13:30 == 47.9	10/8/25 18:00 == 48	10/8/25 22:30 == 48	10/9/25 3:00 == 48
10/8/25 13:35 == 48	10/8/25 18:05 == 48.1	10/8/25 22:35 == 47.9	10/9/25 3:05 == 47.9
10/8/25 13:40 == 47.9	10/8/25 18:10 == 48	10/8/25 22:40 == 48	10/9/25 3:10 == 47.9
10/8/25 13:45 == 47.7	10/8/25 18:15 == 48.1	10/8/25 22:45 == 47.9	10/9/25 3:15 == 48.1
10/8/25 13:50 == 47.9	10/8/25 18:20 == 47.9	10/8/25 22:50 == 47.9	10/9/25 3:20 == 47.8
10/8/25 13:55 == 47.9	10/8/25 18:25 == 48	10/8/25 22:55 == 47.6	10/9/25 3:25 == 47.5
10/8/25 14:00 == 48	10/8/25 18:30 == 48	10/8/25 23:00 == 47.8	10/9/25 3:30 == 48
10/8/25 14:05 == 48	10/8/25 18:35 == 48	10/8/25 23:05 == 48	10/9/25 3:35 == 47.9
10/8/25 14:10 == 48.1	10/8/25 18:40 == 47.9	10/8/25 23:10 == 48	10/9/25 3:40 == 47.4
10/8/25 14:15 == 48.1	10/8/25 18:45 == 47.9	10/8/25 23:15 == 48.1	10/9/25 3:45 == 47.9
10/8/25 14:20 == 48	10/8/25 18:50 == 48	10/8/25 23:20 == 48.2	10/9/25 3:50 == 47.8
10/8/25 14:25 == 47.8	10/8/25 18:55 == 48	10/8/25 23:25 == 48	10/9/25 3:55 == 48.1
10/8/25 14:30 == 47.9	10/8/25 19:00 == 48	10/8/25 23:30 == 47.9	10/9/25 4:00 == 48
10/8/25 14:35 == 47.9	10/8/25 19:05 == 48	10/8/25 23:35 == 48.1	10/9/25 4:05 == 48
10/8/25 14:40 == 48.1	10/8/25 19:10 == 48.1	10/8/25 23:40 == 47.9	10/9/25 4:10 == 48.1
10/8/25 14:45 == 48	10/8/25 19:15 == 48	10/8/25 23:45 == 48	10/9/25 4:15 == 47.9
10/8/25 14:50 == 48.1	10/8/25 19:20 == 47.9	10/8/25 23:50 == 48	10/9/25 4:20 == 48
10/8/25 14:55 == 47.3	10/8/25 19:25 == 48	10/8/25 23:55 == 47.9	10/9/25 4:25 == 48
10/8/25 15:00 == 48.1	10/8/25 19:30 == 48	10/9/25 0:00 == 47.9	10/9/25 4:30 == 48.1
10/8/25 15:05 == 48.1	10/8/25 19:35 == 47.9	10/9/25 0:05 == 47.8	10/9/25 4:35 == 48.1
10/8/25 15:10 == 48	10/8/25 19:40 == 47.8	10/9/25 0:10 == 47.7	10/9/25 4:40 == 48.1
10/8/25 15:15 == 48	10/8/25 19:45 == 48.1	10/9/25 0:15 == 47.7	10/9/25 4:45 == 48
10/8/25 15:20 == 48.1	10/8/25 19:50 == 48	10/9/25 0:20 == 47.9	10/9/25 4:50 == 48.1
10/8/25 15:25 == 48	10/8/25 19:55 == 47.9	10/9/25 0:25 == 47.9	10/9/25 4:55 == 47.6
10/8/25 15:30 == 48	10/8/25 20:00 == 48.2	10/9/25 0:30 == 48	10/9/25 5:00 == 47.7
10/8/25 15:35 == 48	10/8/25 20:05 == 48.1	10/9/25 0:35 == 48	10/9/25 5:05 == 48
10/8/25 15:40 == 48	10/8/25 20:10 == 47.5	10/9/25 0:40 == 48.1	10/9/25 5:10 == 48
10/8/25 15:45 == 48	10/8/25 20:15 == 48	10/9/25 0:45 == 48	10/9/25 5:15 == 48
10/8/25 15:50 == 48	10/8/25 20:20 == 47.9	10/9/25 0:50 == 48	10/9/25 5:20 == 48
10/8/25 15:55 == 47.6	10/8/25 20:25 == 48	10/9/25 0:55 == 47.5	10/9/25 5:25 == 48
10/8/25 16:00 == 47.8	10/8/25 20:30 == 48	10/9/25 1:00 == 47.9	10/9/25 5:30 == 48
10/8/25 16:05 == 45.1	10/8/25 20:35 == 48.2	10/9/25 1:05 == 48.1	10/9/25 5:35 == 47.9
10/8/25 16:10 == 38	10/8/25 20:40 == 47.5	10/9/25 1:10 == 47.9	10/9/25 5:40 == 47.9
10/8/25 16:15 == 34.1	10/8/25 20:45 == 47.6	10/9/25 1:15 == 48	10/9/25 5:45 == 48
10/8/25 16:20 == 34	10/8/25 20:50 == 47.9	10/9/25 1:20 == 48.1	10/9/25 5:50 == 48
10/8/25 16:25 == 33.8	10/8/25 20:55 == 47.9	10/9/25 1:25 == 47.9	10/9/25 5:55 == 48

Pumpback Station Discharge (0364)

10/9/25 6:00 == 48	10/9/25 10:30 == 48.1	10/9/25 15:00 == 48	10/9/25 19:30 == 47.9
10/9/25 6:05 == 48	10/9/25 10:35 == 47.9	10/9/25 15:05 == 48.1	10/9/25 19:35 == 47.9
10/9/25 6:10 == 48	10/9/25 10:40 == 47.7	10/9/25 15:10 == 48	10/9/25 19:40 == 48.1
10/9/25 6:15 == 48.1	10/9/25 10:45 == 47.7	10/9/25 15:15 == 48.1	10/9/25 19:45 == 47.9
10/9/25 6:20 == 48.1	10/9/25 10:50 == 47.8	10/9/25 15:20 == 48	10/9/25 19:50 == 48
10/9/25 6:25 == 48.2	10/9/25 10:55 == 47.8	10/9/25 15:25 == 48	10/9/25 19:55 == 48.1
10/9/25 6:30 == 48.1	10/9/25 11:00 == 47.8	10/9/25 15:30 == 48.1	10/9/25 20:00 == 48
10/9/25 6:35 == 48	10/9/25 11:05 == 48	10/9/25 15:35 == 48	10/9/25 20:05 == 47.6
10/9/25 6:40 == 37	10/9/25 11:10 == 48	10/9/25 15:40 == 48	10/9/25 20:10 == 47.9
10/9/25 6:45 == 33.5	10/9/25 11:15 == 48.1	10/9/25 15:45 == 48	10/9/25 20:15 == 48
10/9/25 6:50 == 33.2	10/9/25 11:20 == 48	10/9/25 15:50 == 47.9	10/9/25 20:20 == 48.2
10/9/25 6:55 == 33.5	10/9/25 11:25 == 47.9	10/9/25 15:55 == 47.8	10/9/25 20:25 == 48.1
10/9/25 7:00 == 33.4	10/9/25 11:30 == 48	10/9/25 16:00 == 47.8	10/9/25 20:30 == 48
10/9/25 7:05 == 33.5	10/9/25 11:35 == 47.9	10/9/25 16:05 == 48	10/9/25 20:35 == 48
10/9/25 7:10 == 42.2	10/9/25 11:40 == 48	10/9/25 16:10 == 48	10/9/25 20:40 == 47.6
10/9/25 7:15 == 47.2	10/9/25 11:45 == 48.1	10/9/25 16:15 == 48.2	10/9/25 20:45 == 47.7
10/9/25 7:20 == 48.1	10/9/25 11:50 == 47.9	10/9/25 16:20 == 48.1	10/9/25 20:50 == 48
10/9/25 7:25 == 47.5	10/9/25 11:55 == 47.8	10/9/25 16:25 == 48	10/9/25 20:55 == 48
10/9/25 7:30 == 47.6	10/9/25 12:00 == 47.9	10/9/25 16:30 == 47.9	10/9/25 21:00 == 48
10/9/25 7:35 == 47.8	10/9/25 12:05 == 48	10/9/25 16:35 == 48.1	10/9/25 21:05 == 48
10/9/25 7:40 == 47.9	10/9/25 12:10 == 48.2	10/9/25 16:40 == 48.1	10/9/25 21:10 == 47.8
10/9/25 7:45 == 47.9	10/9/25 12:15 == 48	10/9/25 16:45 == 48.1	10/9/25 21:15 == 47.9
10/9/25 7:50 == 48	10/9/25 12:20 == 48	10/9/25 16:50 == 47.9	10/9/25 21:20 == 47.9
10/9/25 7:55 == 48	10/9/25 12:25 == 48	10/9/25 16:55 == 47.9	10/9/25 21:25 == 47.8
10/9/25 8:00 == 48	10/9/25 12:30 == 48.1	10/9/25 17:00 == 48.1	10/9/25 21:30 == 48.1
10/9/25 8:05 == 48.1	10/9/25 12:35 == 48	10/9/25 17:05 == 48.1	10/9/25 21:35 == 47.9
10/9/25 8:10 == 48	10/9/25 12:40 == 47.9	10/9/25 17:10 == 48.1	10/9/25 21:40 == 47.9
10/9/25 8:15 == 47.9	10/9/25 12:45 == 48	10/9/25 17:15 == 48.1	10/9/25 21:45 == 48
10/9/25 8:20 == 47.9	10/9/25 12:50 == 48	10/9/25 17:20 == 48	10/9/25 21:50 == 47.8
10/9/25 8:25 == 48	10/9/25 12:55 == 48.1	10/9/25 17:25 == 47.4	10/9/25 21:55 == 48
10/9/25 8:30 == 48.1	10/9/25 13:00 == 48.1	10/9/25 17:30 == 47.7	10/9/25 22:00 == 48
10/9/25 8:35 == 47.8	10/9/25 13:05 == 48.1	10/9/25 17:35 == 47.9	10/9/25 22:05 == 48.1
10/9/25 8:40 == 47.3	10/9/25 13:10 == 48	10/9/25 17:40 == 47.9	10/9/25 22:10 == 47.9
10/9/25 8:45 == 48	10/9/25 13:15 == 47.9	10/9/25 17:45 == 48	10/9/25 22:15 == 47.9
10/9/25 8:50 == 47.9	10/9/25 13:20 == 47.9	10/9/25 17:50 == 48.1	10/9/25 22:20 == 48.1
10/9/25 8:55 == 47.9	10/9/25 13:25 == 47.9	10/9/25 17:55 == 39.7	10/9/25 22:25 == 47.4
10/9/25 9:00 == 47.9	10/9/25 13:30 == 47.9	10/9/25 18:00 == 34.2	10/9/25 22:30 == 47.9
10/9/25 9:05 == 48	10/9/25 13:35 == 46.5	10/9/25 18:05 == 34.2	10/9/25 22:35 == 48
10/9/25 9:10 == 48	10/9/25 13:40 == 40.3	10/9/25 18:10 == 33.9	10/9/25 22:40 == 47.9
10/9/25 9:15 == 48.1	10/9/25 13:45 == 33.5	10/9/25 18:15 == 33.7	10/9/25 22:45 == 48.1
10/9/25 9:20 == 48	10/9/25 13:50 == 33.6	10/9/25 18:20 == 33.6	10/9/25 22:50 == 47.9
10/9/25 9:25 == 48.1	10/9/25 13:55 == 33.6	10/9/25 18:25 == 39.3	10/9/25 22:55 == 47.6
10/9/25 9:30 == 48	10/9/25 14:00 == 33.5	10/9/25 18:30 == 47.8	10/9/25 23:00 == 47.8
10/9/25 9:35 == 48.1	10/9/25 14:05 == 33.9	10/9/25 18:35 == 48	10/9/25 23:05 == 48
10/9/25 9:40 == 48.1	10/9/25 14:10 == 39.7	10/9/25 18:40 == 47.9	10/9/25 23:10 == 48
10/9/25 9:45 == 48.1	10/9/25 14:15 == 47.6	10/9/25 18:45 == 47.9	10/9/25 23:15 == 47.9
10/9/25 9:50 == 48	10/9/25 14:20 == 48.1	10/9/25 18:50 == 47.9	10/9/25 23:20 == 48.1
10/9/25 9:55 == 48	10/9/25 14:25 == 47.9	10/9/25 18:55 == 47.9	10/9/25 23:25 == 48.1
10/9/25 10:00 == 48	10/9/25 14:30 == 48.2	10/9/25 19:00 == 48.1	10/9/25 23:30 == 47.9
10/9/25 10:05 == 48.1	10/9/25 14:35 == 47.9	10/9/25 19:05 == 48.1	10/9/25 23:35 == 48
10/9/25 10:10 == 48.1	10/9/25 14:40 == 47.9	10/9/25 19:10 == 47.9	10/9/25 23:40 == 47.8
10/9/25 10:15 == 48	10/9/25 14:45 == 47.9	10/9/25 19:15 == 48	10/9/25 23:45 == 47.9
10/9/25 10:20 == 48	10/9/25 14:50 == 47.8	10/9/25 19:20 == 48	10/9/25 23:50 == 48
10/9/25 10:25 == 48.1	10/9/25 14:55 == 47.8	10/9/25 19:25 == 48.1	10/9/25 23:55 == 48

Pumpback Station Discharge (0364)

10/10/25 0:00 == 48	10/10/25 4:30 == 48.1	10/10/25 9:00 == 34.8	10/10/25 13:30 == 48.1
10/10/25 0:05 == 47.9	10/10/25 4:35 == 47.9	10/10/25 9:05 == 33.5	10/10/25 13:35 == 48
10/10/25 0:10 == 47.5	10/10/25 4:40 == 48	10/10/25 9:10 == 33.7	10/10/25 13:40 == 48
10/10/25 0:15 == 47.9	10/10/25 4:45 == 48.1	10/10/25 9:15 == 33.6	10/10/25 13:45 == 48.1
10/10/25 0:20 == 48	10/10/25 4:50 == 47.9	10/10/25 9:20 == 33.5	10/10/25 13:50 == 47.9
10/10/25 0:25 == 48	10/10/25 4:55 == 47.8	10/10/25 9:25 == 38.9	10/10/25 13:55 == 48.1
10/10/25 0:30 == 48	10/10/25 5:00 == 47.9	10/10/25 9:30 == 45.6	10/10/25 14:00 == 48.1
10/10/25 0:35 == 48	10/10/25 5:05 == 48.1	10/10/25 9:35 == 48	10/10/25 14:05 == 48
10/10/25 0:40 == 48	10/10/25 5:10 == 48	10/10/25 9:40 == 48	10/10/25 14:10 == 41.4
10/10/25 0:45 == 48.1	10/10/25 5:15 == 48	10/10/25 9:45 == 48	10/10/25 14:15 == 35.3
10/10/25 0:50 == 48.2	10/10/25 5:20 == 47.9	10/10/25 9:50 == 48	10/10/25 14:20 == 33.9
10/10/25 0:55 == 48.1	10/10/25 5:25 == 47.9	10/10/25 9:55 == 48.1	10/10/25 14:25 == 33.7
10/10/25 1:00 == 47.9	10/10/25 5:30 == 48.1	10/10/25 10:00 == 48	10/10/25 14:30 == 33.7
10/10/25 1:05 == 48	10/10/25 5:35 == 47.9	10/10/25 10:05 == 48	10/10/25 14:35 == 33.8
10/10/25 1:10 == 48	10/10/25 5:40 == 48	10/10/25 10:10 == 47.9	10/10/25 14:40 == 38.3
10/10/25 1:15 == 47.8	10/10/25 5:45 == 48	10/10/25 10:15 == 48	10/10/25 14:45 == 44.9
10/10/25 1:20 == 47.9	10/10/25 5:50 == 48.2	10/10/25 10:20 == 48	10/10/25 14:50 == 47.8
10/10/25 1:25 == 48	10/10/25 5:55 == 47.9	10/10/25 10:25 == 48	10/10/25 14:55 == 47.9
10/10/25 1:30 == 48	10/10/25 6:00 == 47.8	10/10/25 10:30 == 47.9	10/10/25 15:00 == 48
10/10/25 1:35 == 48.1	10/10/25 6:05 == 48.1	10/10/25 10:35 == 48.2	10/10/25 15:05 == 48.1
10/10/25 1:40 == 48	10/10/25 6:10 == 47.4	10/10/25 10:40 == 47.6	10/10/25 15:10 == 48
10/10/25 1:45 == 48	10/10/25 6:15 == 47.8	10/10/25 10:45 == 48.1	10/10/25 15:15 == 47.9
10/10/25 1:50 == 47.7	10/10/25 6:20 == 48.1	10/10/25 10:50 == 47.7	10/10/25 15:20 == 48
10/10/25 1:55 == 47.7	10/10/25 6:25 == 48.1	10/10/25 10:55 == 47.5	10/10/25 15:25 == 47.9
10/10/25 2:00 == 47.9	10/10/25 6:30 == 47.9	10/10/25 11:00 == 47.9	10/10/25 15:30 == 47.7
10/10/25 2:05 == 47.9	10/10/25 6:35 == 47.9	10/10/25 11:05 == 48.1	10/10/25 15:35 == 48
10/10/25 2:10 == 48	10/10/25 6:40 == 48	10/10/25 11:10 == 48	10/10/25 15:40 == 48
10/10/25 2:15 == 48.1	10/10/25 6:45 == 47.8	10/10/25 11:15 == 48.2	10/10/25 15:45 == 48
10/10/25 2:20 == 47.9	10/10/25 6:50 == 48	10/10/25 11:20 == 47.9	10/10/25 15:50 == 47.8
10/10/25 2:25 == 47.6	10/10/25 6:55 == 47.8	10/10/25 11:25 == 48	10/10/25 15:55 == 47.4
10/10/25 2:30 == 47.8	10/10/25 7:00 == 47.7	10/10/25 11:30 == 48	10/10/25 16:00 == 47.8
10/10/25 2:35 == 48	10/10/25 7:05 == 47.9	10/10/25 11:35 == 48	10/10/25 16:05 == 48.1
10/10/25 2:40 == 47.9	10/10/25 7:10 == 47.7	10/10/25 11:40 == 48	10/10/25 16:10 == 47.9
10/10/25 2:45 == 47.8	10/10/25 7:15 == 47.7	10/10/25 11:45 == 48	10/10/25 16:15 == 48.1
10/10/25 2:50 == 47.9	10/10/25 7:20 == 47.8	10/10/25 11:50 == 48.1	10/10/25 16:20 == 48.1
10/10/25 2:55 == 48.2	10/10/25 7:25 == 47.9	10/10/25 11:55 == 47.5	10/10/25 16:25 == 47.9
10/10/25 3:00 == 48	10/10/25 7:30 == 48.1	10/10/25 12:00 == 47.7	10/10/25 16:30 == 48.1
10/10/25 3:05 == 48.2	10/10/25 7:35 == 48	10/10/25 12:05 == 48.1	10/10/25 16:35 == 48.2
10/10/25 3:10 == 48	10/10/25 7:40 == 47.7	10/10/25 12:10 == 48	10/10/25 16:40 == 47.9
10/10/25 3:15 == 48	10/10/25 7:45 == 48	10/10/25 12:15 == 48	10/10/25 16:45 == 48
10/10/25 3:20 == 47.8	10/10/25 7:50 == 48.1	10/10/25 12:20 == 48.1	10/10/25 16:50 == 47.9
10/10/25 3:25 == 40.8	10/10/25 7:55 == 47.9	10/10/25 12:25 == 48	10/10/25 16:55 == 48
10/10/25 3:30 == 34	10/10/25 8:00 == 48	10/10/25 12:30 == 48	10/10/25 17:00 == 48
10/10/25 3:35 == 33.4	10/10/25 8:05 == 47.9	10/10/25 12:35 == 48.1	10/10/25 17:05 == 48.1
10/10/25 3:40 == 33.8	10/10/25 8:10 == 47.9	10/10/25 12:40 == 48	10/10/25 17:10 == 48
10/10/25 3:45 == 33.5	10/10/25 8:15 == 48.1	10/10/25 12:45 == 47.9	10/10/25 17:15 == 47.9
10/10/25 3:50 == 33.5	10/10/25 8:20 == 48	10/10/25 12:50 == 47.9	10/10/25 17:20 == 48
10/10/25 3:55 == 38.8	10/10/25 8:25 == 47.9	10/10/25 12:55 == 48	10/10/25 17:25 == 47.7
10/10/25 4:00 == 45.5	10/10/25 8:30 == 47.9	10/10/25 13:00 == 48.1	10/10/25 17:30 == 47.7
10/10/25 4:05 == 47.9	10/10/25 8:35 == 48	10/10/25 13:05 == 48.1	10/10/25 17:35 == 48.1
10/10/25 4:10 == 47.7	10/10/25 8:40 == 48	10/10/25 13:10 == 48.1	10/10/25 17:40 == 48.1
10/10/25 4:15 == 47.7	10/10/25 8:45 == 48.1	10/10/25 13:15 == 48.2	10/10/25 17:45 == 47.9
10/10/25 4:20 == 48	10/10/25 8:50 == 48.2	10/10/25 13:20 == 48.1	10/10/25 17:50 == 47.9
10/10/25 4:25 == 48.1	10/10/25 8:55 == 41.2	10/10/25 13:25 == 48	10/10/25 17:55 == 43.8

Pumpback Station Discharge (0364)

10/10/25 18:00 == 34.3	10/10/25 22:30 == 48	10/11/25 3:00 == 48	10/11/25 7:30 == 48.2
10/10/25 18:05 == 34.1	10/10/25 22:35 == 48	10/11/25 3:05 == 48	10/11/25 7:35 == 48.1
10/10/25 18:10 == 34	10/10/25 22:40 == 48	10/11/25 3:10 == 43.9	10/11/25 7:40 == 46.5
10/10/25 18:15 == 34.1	10/10/25 22:45 == 47.9	10/11/25 3:15 == 36.1	10/11/25 7:45 == 34.5
10/10/25 18:20 == 34	10/10/25 22:50 == 48.1	10/11/25 3:20 == 33.5	10/11/25 7:50 == 33.9
10/10/25 18:25 == 35.4	10/10/25 22:55 == 48.1	10/11/25 3:25 == 33.5	10/11/25 7:55 == 33.9
10/10/25 18:30 == 47.2	10/10/25 23:00 == 47.9	10/11/25 3:30 == 33.7	10/11/25 8:00 == 33.7
10/10/25 18:35 == 48	10/10/25 23:05 == 48	10/11/25 3:35 == 33.9	10/11/25 8:05 == 33.8
10/10/25 18:40 == 48	10/10/25 23:10 == 44.6	10/11/25 3:40 == 36.8	10/11/25 8:10 == 33.7
10/10/25 18:45 == 48.1	10/10/25 23:15 == 35.3	10/11/25 3:45 == 43.4	10/11/25 8:15 == 33.5
10/10/25 18:50 == 48	10/10/25 23:20 == 34	10/11/25 3:50 == 47.8	10/11/25 8:20 == 33.5
10/10/25 18:55 == 47.8	10/10/25 23:25 == 33.7	10/11/25 3:55 == 48	10/11/25 8:25 == 35.1
10/10/25 19:00 == 47.9	10/10/25 23:30 == 33.7	10/11/25 4:00 == 48	10/11/25 8:30 == 43.6
10/10/25 19:05 == 47.9	10/10/25 23:35 == 33.6	10/11/25 4:05 == 48.1	10/11/25 8:35 == 47.8
10/10/25 19:10 == 48	10/10/25 23:40 == 34.7	10/11/25 4:10 == 47.9	10/11/25 8:40 == 48
10/10/25 19:15 == 48	10/10/25 23:45 == 46.5	10/11/25 4:15 == 47.7	10/11/25 8:45 == 48.1
10/10/25 19:20 == 48.1	10/10/25 23:50 == 48	10/11/25 4:20 == 48.1	10/11/25 8:50 == 48
10/10/25 19:25 == 48	10/10/25 23:55 == 48.1	10/11/25 4:25 == 47.9	10/11/25 8:55 == 48
10/10/25 19:30 == 47.8	10/11/25 0:00 == 47.9	10/11/25 4:30 == 47.6	10/11/25 9:00 == 48
10/10/25 19:35 == 48	10/11/25 0:05 == 48	10/11/25 4:35 == 47.9	10/11/25 9:05 == 48
10/10/25 19:40 == 48	10/11/25 0:10 == 48.1	10/11/25 4:40 == 48.2	10/11/25 9:10 == 47.9
10/10/25 19:45 == 48	10/11/25 0:15 == 48	10/11/25 4:45 == 48.2	10/11/25 9:15 == 48
10/10/25 19:50 == 48	10/11/25 0:20 == 48	10/11/25 4:50 == 47.8	10/11/25 9:20 == 48
10/10/25 19:55 == 48	10/11/25 0:25 == 48.1	10/11/25 4:55 == 47.3	10/11/25 9:25 == 48
10/10/25 20:00 == 48	10/11/25 0:30 == 48	10/11/25 5:00 == 48.1	10/11/25 9:30 == 47.9
10/10/25 20:05 == 48.1	10/11/25 0:35 == 48.1	10/11/25 5:05 == 47.8	10/11/25 9:35 == 47.9
10/10/25 20:10 == 47.9	10/11/25 0:40 == 48	10/11/25 5:10 == 48.2	10/11/25 9:40 == 48
10/10/25 20:15 == 47.8	10/11/25 0:45 == 48	10/11/25 5:15 == 48.1	10/11/25 9:45 == 48.1
10/10/25 20:20 == 48.1	10/11/25 0:50 == 48.1	10/11/25 5:20 == 48	10/11/25 9:50 == 47.9
10/10/25 20:25 == 48.1	10/11/25 0:55 == 48	10/11/25 5:25 == 48	10/11/25 9:55 == 47.9
10/10/25 20:30 == 48	10/11/25 1:00 == 48.1	10/11/25 5:30 == 47.8	10/11/25 10:00 == 48
10/10/25 20:35 == 47.9	10/11/25 1:05 == 48.2	10/11/25 5:35 == 47.9	10/11/25 10:05 == 48
10/10/25 20:40 == 47.5	10/11/25 1:10 == 48.1	10/11/25 5:40 == 47.9	10/11/25 10:10 == 48
10/10/25 20:45 == 48	10/11/25 1:15 == 47.9	10/11/25 5:45 == 48	10/11/25 10:15 == 48.2
10/10/25 20:50 == 48	10/11/25 1:20 == 48	10/11/25 5:50 == 48	10/11/25 10:20 == 47.9
10/10/25 20:55 == 47.9	10/11/25 1:25 == 47.9	10/11/25 5:55 == 48.1	10/11/25 10:25 == 47.5
10/10/25 21:00 == 48	10/11/25 1:30 == 47.9	10/11/25 6:00 == 48	10/11/25 10:30 == 47.9
10/10/25 21:05 == 48.1	10/11/25 1:35 == 48	10/11/25 6:05 == 48	10/11/25 10:35 == 47.6
10/10/25 21:10 == 48	10/11/25 1:40 == 48	10/11/25 6:10 == 47.6	10/11/25 10:40 == 47.4
10/10/25 21:15 == 47.9	10/11/25 1:45 == 48	10/11/25 6:15 == 47.8	10/11/25 10:45 == 47.8
10/10/25 21:20 == 48	10/11/25 1:50 == 48.1	10/11/25 6:20 == 48	10/11/25 10:50 == 47.9
10/10/25 21:25 == 47.9	10/11/25 1:55 == 48.1	10/11/25 6:25 == 47.7	10/11/25 10:55 == 47.5
10/10/25 21:30 == 47.5	10/11/25 2:00 == 47.9	10/11/25 6:30 == 47.7	10/11/25 11:00 == 47.7
10/10/25 21:35 == 48	10/11/25 2:05 == 47.9	10/11/25 6:35 == 48	10/11/25 11:05 == 47.9
10/10/25 21:40 == 48	10/11/25 2:10 == 47.8	10/11/25 6:40 == 48.1	10/11/25 11:10 == 48.1
10/10/25 21:45 == 47.9	10/11/25 2:15 == 48	10/11/25 6:45 == 48.1	10/11/25 11:15 == 48.1
10/10/25 21:50 == 47.9	10/11/25 2:20 == 48	10/11/25 6:50 == 47.9	10/11/25 11:20 == 48
10/10/25 21:55 == 48	10/11/25 2:25 == 47.7	10/11/25 6:55 == 47.8	10/11/25 11:25 == 48
10/10/25 22:00 == 48	10/11/25 2:30 == 48.1	10/11/25 7:00 == 47.7	10/11/25 11:30 == 48.2
10/10/25 22:05 == 48.1	10/11/25 2:35 == 47.8	10/11/25 7:05 == 48	10/11/25 11:35 == 48.2
10/10/25 22:10 == 47.4	10/11/25 2:40 == 48	10/11/25 7:10 == 47.7	10/11/25 11:40 == 44.6
10/10/25 22:15 == 47.7	10/11/25 2:45 == 47.9	10/11/25 7:15 == 47.9	10/11/25 11:45 == 37.7
10/10/25 22:20 == 48	10/11/25 2:50 == 47.9	10/11/25 7:20 == 47.7	10/11/25 11:50 == 34.4
10/10/25 22:25 == 48	10/11/25 2:55 == 48	10/11/25 7:25 == 48	10/11/25 11:55 == 34.4

Pumpback Station Discharge (0364)

10/11/25 12:00 == 34	10/11/25 16:30 == 48	10/11/25 21:00 == 48	10/12/25 1:30 == 48.1
10/11/25 12:05 == 34.1	10/11/25 16:35 == 48.1	10/11/25 21:05 == 48.2	10/12/25 1:35 == 48
10/11/25 12:10 == 36	10/11/25 16:40 == 48.1	10/11/25 21:10 == 46.2	10/12/25 1:40 == 47.4
10/11/25 12:15 == 43.4	10/11/25 16:45 == 48.1	10/11/25 21:15 == 36.9	10/12/25 1:45 == 48
10/11/25 12:20 == 48.1	10/11/25 16:50 == 48.1	10/11/25 21:20 == 33.7	10/12/25 1:50 == 48
10/11/25 12:25 == 48	10/11/25 16:55 == 47.8	10/11/25 21:25 == 33.5	10/12/25 1:55 == 48
10/11/25 12:30 == 48	10/11/25 17:00 == 47.7	10/11/25 21:30 == 33.5	10/12/25 2:00 == 47.9
10/11/25 12:35 == 48.1	10/11/25 17:05 == 48.1	10/11/25 21:35 == 33.6	10/12/25 2:05 == 47.9
10/11/25 12:40 == 48	10/11/25 17:10 == 48	10/11/25 21:40 == 34.8	10/12/25 2:10 == 47.9
10/11/25 12:45 == 47.9	10/11/25 17:15 == 48.1	10/11/25 21:45 == 42.4	10/12/25 2:15 == 48.1
10/11/25 12:50 == 47.9	10/11/25 17:20 == 48	10/11/25 21:50 == 48.1	10/12/25 2:20 == 48.1
10/11/25 12:55 == 47.9	10/11/25 17:25 == 47.7	10/11/25 21:55 == 48.1	10/12/25 2:25 == 47.5
10/11/25 13:00 == 48.1	10/11/25 17:30 == 47.9	10/11/25 22:00 == 47.9	10/12/25 2:30 == 47.8
10/11/25 13:05 == 48	10/11/25 17:35 == 48	10/11/25 22:05 == 48	10/12/25 2:35 == 48
10/11/25 13:10 == 48	10/11/25 17:40 == 48.1	10/11/25 22:10 == 47.8	10/12/25 2:40 == 46.3
10/11/25 13:15 == 48	10/11/25 17:45 == 48.1	10/11/25 22:15 == 47.4	10/12/25 2:45 == 38.2
10/11/25 13:20 == 47.9	10/11/25 17:50 == 48.1	10/11/25 22:20 == 47.6	10/12/25 2:50 == 33.7
10/11/25 13:25 == 48	10/11/25 17:55 == 47.9	10/11/25 22:25 == 47.6	10/12/25 2:55 == 33.5
10/11/25 13:30 == 48	10/11/25 18:00 == 47.7	10/11/25 22:30 == 47.8	10/12/25 3:00 == 33.4
10/11/25 13:35 == 48.1	10/11/25 18:05 == 47.8	10/11/25 22:35 == 48	10/12/25 3:05 == 33.5
10/11/25 13:40 == 48	10/11/25 18:10 == 47.9	10/11/25 22:40 == 48.1	10/12/25 3:10 == 34.8
10/11/25 13:45 == 48.1	10/11/25 18:15 == 47.9	10/11/25 22:45 == 48	10/12/25 3:15 == 40.9
10/11/25 13:50 == 48	10/11/25 18:20 == 48	10/11/25 22:50 == 47.8	10/12/25 3:20 == 47.8
10/11/25 13:55 == 47.9	10/11/25 18:25 == 46.7	10/11/25 22:55 == 47.5	10/12/25 3:25 == 48
10/11/25 14:00 == 48	10/11/25 18:30 == 36.2	10/11/25 23:00 == 47.8	10/12/25 3:30 == 47.7
10/11/25 14:05 == 47.9	10/11/25 18:35 == 33.6	10/11/25 23:05 == 48	10/12/25 3:35 == 47.7
10/11/25 14:10 == 44.4	10/11/25 18:40 == 33.6	10/11/25 23:10 == 48	10/12/25 3:40 == 47.4
10/11/25 14:15 == 37.5	10/11/25 18:45 == 33.5	10/11/25 23:15 == 47.9	10/12/25 3:45 == 47.6
10/11/25 14:20 == 33.7	10/11/25 18:50 == 33.6	10/11/25 23:20 == 47.9	10/12/25 3:50 == 47.8
10/11/25 14:25 == 33.7	10/11/25 18:55 == 34.4	10/11/25 23:25 == 47.7	10/12/25 3:55 == 47.9
10/11/25 14:30 == 33.7	10/11/25 19:00 == 42.6	10/11/25 23:30 == 47.9	10/12/25 4:00 == 48
10/11/25 14:35 == 33.8	10/11/25 19:05 == 47.8	10/11/25 23:35 == 47.9	10/12/25 4:05 == 48
10/11/25 14:40 == 33.8	10/11/25 19:10 == 48	10/11/25 23:40 == 47.9	10/12/25 4:10 == 48
10/11/25 14:45 == 33.8	10/11/25 19:15 == 48.1	10/11/25 23:45 == 48	10/12/25 4:15 == 48
10/11/25 14:50 == 33.7	10/11/25 19:20 == 47.9	10/11/25 23:50 == 48	10/12/25 4:20 == 48.2
10/11/25 14:55 == 35.2	10/11/25 19:25 == 47.7	10/11/25 23:55 == 46.1	10/12/25 4:25 == 48.1
10/11/25 15:00 == 42.8	10/11/25 19:30 == 47.7	10/12/25 0:00 == 37.4	10/12/25 4:30 == 47.9
10/11/25 15:05 == 47.8	10/11/25 19:35 == 47.9	10/12/25 0:05 == 33.7	10/12/25 4:35 == 48
10/11/25 15:10 == 47.5	10/11/25 19:40 == 48	10/12/25 0:10 == 33.5	10/12/25 4:40 == 48.1
10/11/25 15:15 == 47.9	10/11/25 19:45 == 48	10/12/25 0:15 == 33.5	10/12/25 4:45 == 48
10/11/25 15:20 == 47.9	10/11/25 19:50 == 47.8	10/12/25 0:20 == 33.6	10/12/25 4:50 == 47.8
10/11/25 15:25 == 48.1	10/11/25 19:55 == 47.7	10/12/25 0:25 == 35	10/12/25 4:55 == 47.3
10/11/25 15:30 == 48.1	10/11/25 20:00 == 47.8	10/12/25 0:30 == 41.7	10/12/25 5:00 == 47.8
10/11/25 15:35 == 48.1	10/11/25 20:05 == 48	10/12/25 0:35 == 47.8	10/12/25 5:05 == 48.1
10/11/25 15:40 == 47.9	10/11/25 20:10 == 47.5	10/12/25 0:40 == 47.9	10/12/25 5:10 == 47.9
10/11/25 15:45 == 47.9	10/11/25 20:15 == 48.1	10/12/25 0:45 == 48	10/12/25 5:15 == 47.9
10/11/25 15:50 == 48.1	10/11/25 20:20 == 47.9	10/12/25 0:50 == 48	10/12/25 5:20 == 48
10/11/25 15:55 == 47.4	10/11/25 20:25 == 47.9	10/12/25 0:55 == 48.1	10/12/25 5:25 == 46
10/11/25 16:00 == 47.7	10/11/25 20:30 == 48	10/12/25 1:00 == 47.8	10/12/25 5:30 == 38.7
10/11/25 16:05 == 48.1	10/11/25 20:35 == 48.1	10/12/25 1:05 == 47.9	10/12/25 5:35 == 33.7
10/11/25 16:10 == 48.1	10/11/25 20:40 == 47.5	10/12/25 1:10 == 47.9	10/12/25 5:40 == 33.8
10/11/25 16:15 == 48	10/11/25 20:45 == 48	10/12/25 1:15 == 47.9	10/12/25 5:45 == 33.8
10/11/25 16:20 == 48	10/11/25 20:50 == 48.1	10/12/25 1:20 == 48.1	10/12/25 5:50 == 33.9
10/11/25 16:25 == 48	10/11/25 20:55 == 48	10/12/25 1:25 == 48.2	10/12/25 5:55 == 35.2

Pumpback Station Discharge (0364)

10/12/25 6:00 == 37.3	10/12/25 10:30 == 47.8	10/12/25 15:00 == 48	10/12/25 19:30 == 47.8
10/12/25 6:05 == 16.6	10/12/25 10:35 == 47.5	10/12/25 15:05 == 48	10/12/25 19:35 == 48.1
10/12/25 6:10 == 5.1	10/12/25 10:40 == 47.4	10/12/25 15:10 == 47.6	10/12/25 19:40 == 48
10/12/25 6:15 == 0	10/12/25 10:45 == 47.7	10/12/25 15:15 == 47.8	10/12/25 19:45 == 48.1
10/12/25 6:20 == 0	10/12/25 10:50 == 47.9	10/12/25 15:20 == 48	10/12/25 19:50 == 47.9
10/12/25 6:25 == 0	10/12/25 10:55 == 47.7	10/12/25 15:25 == 48	10/12/25 19:55 == 48
10/12/25 6:30 == 0	10/12/25 11:00 == 47.9	10/12/25 15:30 == 47.9	10/12/25 20:00 == 47.9
10/12/25 6:35 == 0	10/12/25 11:05 == 48.1	10/12/25 15:35 == 47.9	10/12/25 20:05 == 48
10/12/25 6:40 == 0	10/12/25 11:10 == 47.9	10/12/25 15:40 == 47.9	10/12/25 20:10 == 47.6
10/12/25 6:45 == 0	10/12/25 11:15 == 47.6	10/12/25 15:45 == 48	10/12/25 20:15 == 47.9
10/12/25 6:50 == 1.6	10/12/25 11:20 == 47.9	10/12/25 15:50 == 47.9	10/12/25 20:20 == 47.9
10/12/25 6:55 == 8.5	10/12/25 11:25 == 48	10/12/25 15:55 == 47.8	10/12/25 20:25 == 48
10/12/25 7:00 == 18	10/12/25 11:30 == 47.9	10/12/25 16:00 == 47.9	10/12/25 20:30 == 48
10/12/25 7:05 == 26.1	10/12/25 11:35 == 47.9	10/12/25 16:05 == 48.1	10/12/25 20:35 == 48.1
10/12/25 7:10 == 46	10/12/25 11:40 == 48	10/12/25 16:10 == 47.9	10/12/25 20:40 == 47.6
10/12/25 7:15 == 47.9	10/12/25 11:45 == 48.1	10/12/25 16:15 == 47.7	10/12/25 20:45 == 47.6
10/12/25 7:20 == 47.9	10/12/25 11:50 == 48.1	10/12/25 16:20 == 48	10/12/25 20:50 == 48
10/12/25 7:25 == 0	10/12/25 11:55 == 47.1	10/12/25 16:25 == 48	10/12/25 20:55 == 48
10/12/25 7:30 == 0	10/12/25 12:00 == 48	10/12/25 16:30 == 48.1	10/12/25 21:00 == 47.9
10/12/25 7:35 == 0	10/12/25 12:05 == 48.1	10/12/25 16:35 == 48	10/12/25 21:05 == 47.9
10/12/25 7:40 == 0	10/12/25 12:10 == 47.6	10/12/25 16:40 == 47.9	10/12/25 21:10 == 48
10/12/25 7:45 == 0	10/12/25 12:15 == 48	10/12/25 16:45 == 48	10/12/25 21:15 == 48
10/12/25 7:50 == 0	10/12/25 12:20 == 47.8	10/12/25 16:50 == 48	10/12/25 21:20 == 47.8
10/12/25 7:55 == 0	10/12/25 12:25 == 48	10/12/25 16:55 == 48	10/12/25 21:25 == 47.4
10/12/25 8:00 == 0	10/12/25 12:30 == 48	10/12/25 17:00 == 48	10/12/25 21:30 == 47.7
10/12/25 8:05 == 0	10/12/25 12:35 == 48.1	10/12/25 17:05 == 48	10/12/25 21:35 == 48
10/12/25 8:10 == 0	10/12/25 12:40 == 47.9	10/12/25 17:10 == 47.8	10/12/25 21:40 == 48
10/12/25 8:15 == 4.5	10/12/25 12:45 == 47.9	10/12/25 17:15 == 47.6	10/12/25 21:45 == 47.9
10/12/25 8:20 == 22.9	10/12/25 12:50 == 47.9	10/12/25 17:20 == 47.8	10/12/25 21:50 == 48.1
10/12/25 8:25 == 44.2	10/12/25 12:55 == 48	10/12/25 17:25 == 47.5	10/12/25 21:55 == 47.9
10/12/25 8:30 == 47.9	10/12/25 13:00 == 47.9	10/12/25 17:30 == 47.9	10/12/25 22:00 == 48
10/12/25 8:35 == 48.1	10/12/25 13:05 == 48	10/12/25 17:35 == 48.2	10/12/25 22:05 == 47.9
10/12/25 8:40 == 48	10/12/25 13:10 == 48.1	10/12/25 17:40 == 48	10/12/25 22:10 == 47.4
10/12/25 8:45 == 48	10/12/25 13:15 == 47.9	10/12/25 17:45 == 47.9	10/12/25 22:15 == 47.4
10/12/25 8:50 == 48	10/12/25 13:20 == 47.9	10/12/25 17:50 == 48	10/12/25 22:20 == 48
10/12/25 8:55 == 48.1	10/12/25 13:25 == 47.9	10/12/25 17:55 == 47.5	10/12/25 22:25 == 47.4
10/12/25 9:00 == 47.9	10/12/25 13:30 == 47.8	10/12/25 18:00 == 47.6	10/12/25 22:30 == 47.8
10/12/25 9:05 == 48.1	10/12/25 13:35 == 48	10/12/25 18:05 == 47.9	10/12/25 22:35 == 48
10/12/25 9:10 == 48	10/12/25 13:40 == 48	10/12/25 18:10 == 48	10/12/25 22:40 == 47.6
10/12/25 9:15 == 48.1	10/12/25 13:45 == 48.1	10/12/25 18:15 == 48	10/12/25 22:45 == 48
10/12/25 9:20 == 48.1	10/12/25 13:50 == 48	10/12/25 18:20 == 48	10/12/25 22:50 == 48
10/12/25 9:25 == 47.5	10/12/25 13:55 == 48	10/12/25 18:25 == 47.9	10/12/25 22:55 == 48
10/12/25 9:30 == 47.2	10/12/25 14:00 == 47.9	10/12/25 18:30 == 48	10/12/25 23:00 == 48.1
10/12/25 9:35 == 47.9	10/12/25 14:05 == 48	10/12/25 18:35 == 48.1	10/12/25 23:05 == 48.1
10/12/25 9:40 == 47.9	10/12/25 14:10 == 47.8	10/12/25 18:40 == 48	10/12/25 23:10 == 48
10/12/25 9:45 == 47.9	10/12/25 14:15 == 47.7	10/12/25 18:45 == 48.1	10/12/25 23:15 == 48.1
10/12/25 9:50 == 48	10/12/25 14:20 == 47.9	10/12/25 18:50 == 48.1	10/12/25 23:20 == 48.1
10/12/25 9:55 == 47.9	10/12/25 14:25 == 48	10/12/25 18:55 == 48	10/12/25 23:25 == 47.8
10/12/25 10:00 == 47.9	10/12/25 14:30 == 48.1	10/12/25 19:00 == 47.9	10/12/25 23:30 == 47.7
10/12/25 10:05 == 48.1	10/12/25 14:35 == 48.3	10/12/25 19:05 == 48	10/12/25 23:35 == 48
10/12/25 10:10 == 48.2	10/12/25 14:40 == 47.9	10/12/25 19:10 == 48.1	10/12/25 23:40 == 48
10/12/25 10:15 == 48.1	10/12/25 14:45 == 48.1	10/12/25 19:15 == 47.9	10/12/25 23:45 == 48
10/12/25 10:20 == 48	10/12/25 14:50 == 48	10/12/25 19:20 == 48	10/12/25 23:50 == 48
10/12/25 10:25 == 47.9	10/12/25 14:55 == 48.1	10/12/25 19:25 == 47.3	10/12/25 23:55 == 46.7

Pumpback Station Discharge (0364)

10/13/25 0:00 == 40.9	10/13/25 4:30 == 48	10/13/25 9:00 == 48	10/13/25 13:30 == 48
10/13/25 0:05 == 33.5	10/13/25 4:35 == 48	10/13/25 9:05 == 48	10/13/25 13:35 == 47.9
10/13/25 0:10 == 33.8	10/13/25 4:40 == 48.1	10/13/25 9:10 == 48.1	10/13/25 13:40 == 48
10/13/25 0:15 == 33.5	10/13/25 4:45 == 48.1	10/13/25 9:15 == 48	10/13/25 13:45 == 48.1
10/13/25 0:20 == 33.6	10/13/25 4:50 == 48	10/13/25 9:20 == 48.1	10/13/25 13:50 == 48
10/13/25 0:25 == 34.1	10/13/25 4:55 == 47.9	10/13/25 9:25 == 47.7	10/13/25 13:55 == 48
10/13/25 0:30 == 38.7	10/13/25 5:00 == 48	10/13/25 9:30 == 47.8	10/13/25 14:00 == 48
10/13/25 0:35 == 47.6	10/13/25 5:05 == 48	10/13/25 9:35 == 48	10/13/25 14:05 == 48.1
10/13/25 0:40 == 48.1	10/13/25 5:10 == 48	10/13/25 9:40 == 48	10/13/25 14:10 == 47.5
10/13/25 0:45 == 48.1	10/13/25 5:15 == 48	10/13/25 9:45 == 48	10/13/25 14:15 == 47.7
10/13/25 0:50 == 47.8	10/13/25 5:20 == 48.1	10/13/25 9:50 == 48	10/13/25 14:20 == 48
10/13/25 0:55 == 47.8	10/13/25 5:25 == 48	10/13/25 9:55 == 48.2	10/13/25 14:25 == 48.1
10/13/25 1:00 == 48.1	10/13/25 5:30 == 48	10/13/25 10:00 == 48.1	10/13/25 14:30 == 41
10/13/25 1:05 == 48	10/13/25 5:35 == 47.8	10/13/25 10:05 == 48	10/13/25 14:35 == 35.2
10/13/25 1:10 == 48.2	10/13/25 5:40 == 48.1	10/13/25 10:10 == 47.2	10/13/25 14:40 == 33.9
10/13/25 1:15 == 48	10/13/25 5:45 == 47.9	10/13/25 10:15 == 42	10/13/25 14:45 == 33.8
10/13/25 1:20 == 48.2	10/13/25 5:50 == 48	10/13/25 10:20 == 33.2	10/13/25 14:50 == 33.9
10/13/25 1:25 == 47.5	10/13/25 5:55 == 48	10/13/25 10:25 == 33.4	10/13/25 14:55 == 33.9
10/13/25 1:30 == 47.9	10/13/25 6:00 == 48	10/13/25 10:30 == 33.2	10/13/25 15:00 == 33.8
10/13/25 1:35 == 48.1	10/13/25 6:05 == 48	10/13/25 10:35 == 33.1	10/13/25 15:05 == 33.9
10/13/25 1:40 == 48	10/13/25 6:10 == 48	10/13/25 10:40 == 34.1	10/13/25 15:10 == 34
10/13/25 1:45 == 47.9	10/13/25 6:15 == 48	10/13/25 10:45 == 37	10/13/25 15:15 == 38
10/13/25 1:50 == 48	10/13/25 6:20 == 48.1	10/13/25 10:50 == 47.5	10/13/25 15:20 == 46.7
10/13/25 1:55 == 48.1	10/13/25 6:25 == 47.6	10/13/25 10:55 == 47.2	10/13/25 15:25 == 48.1
10/13/25 2:00 == 48	10/13/25 6:30 == 47.9	10/13/25 11:00 == 47.8	10/13/25 15:30 == 48
10/13/25 2:05 == 47.9	10/13/25 6:35 == 48	10/13/25 11:05 == 48	10/13/25 15:35 == 48
10/13/25 2:10 == 47.9	10/13/25 6:40 == 47.7	10/13/25 11:10 == 48.1	10/13/25 15:40 == 48.1
10/13/25 2:15 == 47.9	10/13/25 6:45 == 47.9	10/13/25 11:15 == 48.2	10/13/25 15:45 == 47.9
10/13/25 2:20 == 47.7	10/13/25 6:50 == 48	10/13/25 11:20 == 48	10/13/25 15:50 == 47.9
10/13/25 2:25 == 47.6	10/13/25 6:55 == 47.5	10/13/25 11:25 == 48	10/13/25 15:55 == 47.4
10/13/25 2:30 == 47.9	10/13/25 7:00 == 47.7	10/13/25 11:30 == 48.2	10/13/25 16:00 == 48
10/13/25 2:35 == 48	10/13/25 7:05 == 48	10/13/25 11:35 == 48	10/13/25 16:05 == 47.9
10/13/25 2:40 == 47	10/13/25 7:10 == 47.3	10/13/25 11:40 == 48.1	10/13/25 16:10 == 47.9
10/13/25 2:45 == 41.4	10/13/25 7:15 == 41	10/13/25 11:45 == 48.1	10/13/25 16:15 == 48.1
10/13/25 2:50 == 33.5	10/13/25 7:20 == 34.3	10/13/25 11:50 == 47.9	10/13/25 16:20 == 48.1
10/13/25 2:55 == 33.6	10/13/25 7:25 == 34.1	10/13/25 11:55 == 47	10/13/25 16:25 == 48.2
10/13/25 3:00 == 33.5	10/13/25 7:30 == 34	10/13/25 12:00 == 47.5	10/13/25 16:30 == 47.8
10/13/25 3:05 == 33.4	10/13/25 7:35 == 34	10/13/25 12:05 == 48	10/13/25 16:35 == 48
10/13/25 3:10 == 33.6	10/13/25 7:40 == 34	10/13/25 12:10 == 48	10/13/25 16:40 == 48
10/13/25 3:15 == 38.2	10/13/25 7:45 == 37.6	10/13/25 12:15 == 48	10/13/25 16:45 == 48
10/13/25 3:20 == 47.7	10/13/25 7:50 == 48	10/13/25 12:20 == 48	10/13/25 16:50 == 47.9
10/13/25 3:25 == 47.9	10/13/25 7:55 == 48	10/13/25 12:25 == 48	10/13/25 16:55 == 47.9
10/13/25 3:30 == 48	10/13/25 8:00 == 47.9	10/13/25 12:30 == 48	10/13/25 17:00 == 48
10/13/25 3:35 == 48.1	10/13/25 8:05 == 48	10/13/25 12:35 == 47.8	10/13/25 17:05 == 48
10/13/25 3:40 == 47.4	10/13/25 8:10 == 47.8	10/13/25 12:40 == 47.6	10/13/25 17:10 == 47.9
10/13/25 3:45 == 47.9	10/13/25 8:15 == 47.3	10/13/25 12:45 == 48.2	10/13/25 17:15 == 47.9
10/13/25 3:50 == 48	10/13/25 8:20 == 48	10/13/25 12:50 == 48.2	10/13/25 17:20 == 48.1
10/13/25 3:55 == 48	10/13/25 8:25 == 47.8	10/13/25 12:55 == 48.1	10/13/25 17:25 == 47.8
10/13/25 4:00 == 47.9	10/13/25 8:30 == 48	10/13/25 13:00 == 48	10/13/25 17:30 == 47.8
10/13/25 4:05 == 48.1	10/13/25 8:35 == 48	10/13/25 13:05 == 47.9	10/13/25 17:35 == 48.2
10/13/25 4:10 == 47.6	10/13/25 8:40 == 47.6	10/13/25 13:10 == 48.1	10/13/25 17:40 == 48.1
10/13/25 4:15 == 47.8	10/13/25 8:45 == 47.8	10/13/25 13:15 == 48.1	10/13/25 17:45 == 48
10/13/25 4:20 == 48	10/13/25 8:50 == 48	10/13/25 13:20 == 48.1	10/13/25 17:50 == 48.1
10/13/25 4:25 == 48	10/13/25 8:55 == 48	10/13/25 13:25 == 48	10/13/25 17:55 == 48

Pumpback Station Discharge (0364)

10/13/25 18:00 == 48	10/13/25 22:30 == 42	10/14/25 3:00 == 47.9	10/14/25 7:30 == 48.1
10/13/25 18:05 == 48	10/13/25 22:35 == 35.7	10/14/25 3:05 == 48	10/14/25 7:35 == 48
10/13/25 18:10 == 47.9	10/13/25 22:40 == 34.3	10/14/25 3:10 == 48.1	10/14/25 7:40 == 48.1
10/13/25 18:15 == 47.9	10/13/25 22:45 == 34.3	10/14/25 3:15 == 48.1	10/14/25 7:45 == 47.8
10/13/25 18:20 == 47.9	10/13/25 22:50 == 34.3	10/14/25 3:20 == 48.1	10/14/25 7:50 == 48.3
10/13/25 18:25 == 47.8	10/13/25 22:55 == 34.4	10/14/25 3:25 == 48	10/14/25 7:55 == 48
10/13/25 18:30 == 48.3	10/13/25 23:00 == 37.8	10/14/25 3:30 == 48	10/14/25 8:00 == 48
10/13/25 18:35 == 47.9	10/13/25 23:05 == 46	10/14/25 3:35 == 47.9	10/14/25 8:05 == 48
10/13/25 18:40 == 48	10/13/25 23:10 == 48	10/14/25 3:40 == 47.7	10/14/25 8:10 == 48
10/13/25 18:45 == 42.8	10/13/25 23:15 == 48	10/14/25 3:45 == 47.7	10/14/25 8:15 == 47.8
10/13/25 18:50 == 33.9	10/13/25 23:20 == 48	10/14/25 3:50 == 47.9	10/14/25 8:20 == 47.9
10/13/25 18:55 == 33.7	10/13/25 23:25 == 47.7	10/14/25 3:55 == 48	10/14/25 8:25 == 47.6
10/13/25 19:00 == 33.7	10/13/25 23:30 == 48	10/14/25 4:00 == 48.2	10/14/25 8:30 == 47.7
10/13/25 19:05 == 33.6	10/13/25 23:35 == 48	10/14/25 4:05 == 47.9	10/14/25 8:35 == 47.9
10/13/25 19:10 == 33.5	10/13/25 23:40 == 47.9	10/14/25 4:10 == 47.7	10/14/25 8:40 == 48
10/13/25 19:15 == 37.8	10/13/25 23:45 == 48	10/14/25 4:15 == 47.8	10/14/25 8:45 == 48
10/13/25 19:20 == 45.7	10/13/25 23:50 == 48	10/14/25 4:20 == 48	10/14/25 8:50 == 47.9
10/13/25 19:25 == 47.5	10/13/25 23:55 == 48	10/14/25 4:25 == 48.1	10/14/25 8:55 == 47.9
10/13/25 19:30 == 47.8	10/14/25 0:00 == 47.9	10/14/25 4:30 == 48	10/14/25 9:00 == 48
10/13/25 19:35 == 48.1	10/14/25 0:05 == 48.1	10/14/25 4:35 == 47.9	10/14/25 9:05 == 48
10/13/25 19:40 == 48	10/14/25 0:10 == 47.4	10/14/25 4:40 == 47.9	10/14/25 9:10 == 47.9
10/13/25 19:45 == 48	10/14/25 0:15 == 47.7	10/14/25 4:45 == 48.1	10/14/25 9:15 == 47.9
10/13/25 19:50 == 47.9	10/14/25 0:20 == 48	10/14/25 4:50 == 48	10/14/25 9:20 == 48
10/13/25 19:55 == 47.5	10/14/25 0:25 == 48	10/14/25 4:55 == 47.6	10/14/25 9:25 == 48
10/13/25 20:00 == 47.6	10/14/25 0:30 == 48	10/14/25 5:00 == 48	10/14/25 9:30 == 48
10/13/25 20:05 == 47.9	10/14/25 0:35 == 47.9	10/14/25 5:05 == 48	10/14/25 9:35 == 48
10/13/25 20:10 == 47.7	10/14/25 0:40 == 47.9	10/14/25 5:10 == 48.1	10/14/25 9:40 == 48.1
10/13/25 20:15 == 47.7	10/14/25 0:45 == 47.8	10/14/25 5:15 == 47.9	10/14/25 9:45 == 47.9
10/13/25 20:20 == 48	10/14/25 0:50 == 48	10/14/25 5:20 == 48	10/14/25 9:50 == 47.5
10/13/25 20:25 == 48.1	10/14/25 0:55 == 48	10/14/25 5:25 == 48	10/14/25 9:55 == 48
10/13/25 20:30 == 48	10/14/25 1:00 == 48	10/14/25 5:30 == 48.1	10/14/25 10:00 == 48.1
10/13/25 20:35 == 47.7	10/14/25 1:05 == 48.1	10/14/25 5:35 == 47.9	10/14/25 10:05 == 48.2
10/13/25 20:40 == 47.6	10/14/25 1:10 == 47.8	10/14/25 5:40 == 47.9	10/14/25 10:10 == 47.9
10/13/25 20:45 == 47.9	10/14/25 1:15 == 47.6	10/14/25 5:45 == 43.2	10/14/25 10:15 == 48
10/13/25 20:50 == 47.9	10/14/25 1:20 == 48	10/14/25 5:50 == 36.3	10/14/25 10:20 == 48.1
10/13/25 20:55 == 47.8	10/14/25 1:25 == 48.1	10/14/25 5:55 == 33.9	10/14/25 10:25 == 47.1
10/13/25 21:00 == 48	10/14/25 1:30 == 48.1	10/14/25 6:00 == 33.8	10/14/25 10:30 == 47.9
10/13/25 21:05 == 48	10/14/25 1:35 == 48.1	10/14/25 6:05 == 33.8	10/14/25 10:35 == 48
10/13/25 21:10 == 47.9	10/14/25 1:40 == 48.1	10/14/25 6:10 == 33.8	10/14/25 10:40 == 47.6
10/13/25 21:15 == 48	10/14/25 1:45 == 44.6	10/14/25 6:15 == 37.1	10/14/25 10:45 == 47.7
10/13/25 21:20 == 47.9	10/14/25 1:50 == 34.2	10/14/25 6:20 == 43.6	10/14/25 10:50 == 48.1
10/13/25 21:25 == 47.9	10/14/25 1:55 == 34.4	10/14/25 6:25 == 47.7	10/14/25 10:55 == 48.1
10/13/25 21:30 == 47.6	10/14/25 2:00 == 34.3	10/14/25 6:30 == 48	10/14/25 11:00 == 47.9
10/13/25 21:35 == 48	10/14/25 2:05 == 34.1	10/14/25 6:35 == 48	10/14/25 11:05 == 47.9
10/13/25 21:40 == 47.9	10/14/25 2:10 == 33.8	10/14/25 6:40 == 47.9	10/14/25 11:10 == 48
10/13/25 21:45 == 48	10/14/25 2:15 == 33.8	10/14/25 6:45 == 48	10/14/25 11:15 == 48
10/13/25 21:50 == 47.9	10/14/25 2:20 == 45.9	10/14/25 6:50 == 48	10/14/25 11:20 == 48
10/13/25 21:55 == 47.4	10/14/25 2:25 == 47.2	10/14/25 6:55 == 47.7	10/14/25 11:25 == 48
10/13/25 22:00 == 47.7	10/14/25 2:30 == 48.1	10/14/25 7:00 == 47.7	10/14/25 11:30 == 48
10/13/25 22:05 == 48.1	10/14/25 2:35 == 48	10/14/25 7:05 == 47.8	10/14/25 11:35 == 47.9
10/13/25 22:10 == 47.8	10/14/25 2:40 == 48	10/14/25 7:10 == 47.4	10/14/25 11:40 == 47.9
10/13/25 22:15 == 47.9	10/14/25 2:45 == 48.1	10/14/25 7:15 == 47.7	10/14/25 11:45 == 48
10/13/25 22:20 == 48.1	10/14/25 2:50 == 48	10/14/25 7:20 == 47.9	10/14/25 11:50 == 47.9
10/13/25 22:25 == 47.8	10/14/25 2:55 == 47.9	10/14/25 7:25 == 47.9	10/14/25 11:55 == 47.7

Pumpback Station Discharge (0364)

10/14/25 12:00 == 47.6	10/14/25 16:30 == 48	10/14/25 21:00 == 47.8	10/15/25 1:30 == 48
10/14/25 12:05 == 47.7	10/14/25 16:35 == 48	10/14/25 21:05 == 48	10/15/25 1:35 == 48
10/14/25 12:10 == 47.4	10/14/25 16:40 == 48	10/14/25 21:10 == 48.1	10/15/25 1:40 == 47.8
10/14/25 12:15 == 47.8	10/14/25 16:45 == 48	10/14/25 21:15 == 48	10/15/25 1:45 == 48
10/14/25 12:20 == 48	10/14/25 16:50 == 47.7	10/14/25 21:20 == 48.2	10/15/25 1:50 == 48.1
10/14/25 12:25 == 48	10/14/25 16:55 == 47.5	10/14/25 21:25 == 47.7	10/15/25 1:55 == 48
10/14/25 12:30 == 47.4	10/14/25 17:00 == 47.7	10/14/25 21:30 == 47.7	10/15/25 2:00 == 47.8
10/14/25 12:35 == 48.2	10/14/25 17:05 == 47.9	10/14/25 21:35 == 47.9	10/15/25 2:05 == 48.1
10/14/25 12:40 == 47.8	10/14/25 17:10 == 47.7	10/14/25 21:40 == 47.9	10/15/25 2:10 == 48
10/14/25 12:45 == 48.1	10/14/25 17:15 == 48	10/14/25 21:45 == 47.9	10/15/25 2:15 == 47.8
10/14/25 12:50 == 48	10/14/25 17:20 == 47.8	10/14/25 21:50 == 47.9	10/15/25 2:20 == 48
10/14/25 12:55 == 47.9	10/14/25 17:25 == 47.5	10/14/25 21:55 == 48	10/15/25 2:25 == 47.6
10/14/25 13:00 == 48	10/14/25 17:30 == 47.9	10/14/25 22:00 == 48.1	10/15/25 2:30 == 47.8
10/14/25 13:05 == 48.1	10/14/25 17:35 == 48	10/14/25 22:05 == 48	10/15/25 2:35 == 48
10/14/25 13:10 == 48.1	10/14/25 17:40 == 48.2	10/14/25 22:10 == 48	10/15/25 2:40 == 48
10/14/25 13:15 == 48.1	10/14/25 17:45 == 47.8	10/14/25 22:15 == 48	10/15/25 2:45 == 48
10/14/25 13:20 == 47.8	10/14/25 17:50 == 47.9	10/14/25 22:20 == 48	10/15/25 2:50 == 47.9
10/14/25 13:25 == 47.8	10/14/25 17:55 == 48.2	10/14/25 22:25 == 48.1	10/15/25 2:55 == 47.8
10/14/25 13:30 == 48	10/14/25 18:00 == 48	10/14/25 22:30 == 48	10/15/25 3:00 == 47.9
10/14/25 13:35 == 47.7	10/14/25 18:05 == 48.2	10/14/25 22:35 == 47.7	10/15/25 3:05 == 47.9
10/14/25 13:40 == 47.7	10/14/25 18:10 == 48	10/14/25 22:40 == 48	10/15/25 3:10 == 47.9
10/14/25 13:45 == 47.5	10/14/25 18:15 == 48.1	10/14/25 22:45 == 47.9	10/15/25 3:15 == 47.9
10/14/25 13:50 == 47.6	10/14/25 18:20 == 48	10/14/25 22:50 == 48.1	10/15/25 3:20 == 48
10/14/25 13:55 == 48	10/14/25 18:25 == 47.8	10/14/25 22:55 == 48.1	10/15/25 3:25 == 48
10/14/25 14:00 == 48.1	10/14/25 18:30 == 47.9	10/14/25 23:00 == 48.3	10/15/25 3:30 == 48
10/14/25 14:05 == 48.1	10/14/25 18:35 == 48	10/14/25 23:05 == 47.3	10/15/25 3:35 == 47.8
10/14/25 14:10 == 48	10/14/25 18:40 == 48.1	10/14/25 23:10 == 48	10/15/25 3:40 == 47.3
10/14/25 14:15 == 48	10/14/25 18:45 == 48.1	10/14/25 23:15 == 48	10/15/25 3:45 == 47.9
10/14/25 14:20 == 48	10/14/25 18:50 == 48.1	10/14/25 23:20 == 47.9	10/15/25 3:50 == 48
10/14/25 14:25 == 48	10/14/25 18:55 == 48	10/14/25 23:25 == 47.9	10/15/25 3:55 == 48
10/14/25 14:30 == 48.1	10/14/25 19:00 == 47.9	10/14/25 23:30 == 48	10/15/25 4:00 == 47.9
10/14/25 14:35 == 48	10/14/25 19:05 == 47.8	10/14/25 23:35 == 48	10/15/25 4:05 == 48
10/14/25 14:40 == 48.1	10/14/25 19:10 == 47.8	10/14/25 23:40 == 48.1	10/15/25 4:10 == 48
10/14/25 14:45 == 47.9	10/14/25 19:15 == 47.8	10/14/25 23:45 == 47.9	10/15/25 4:15 == 48
10/14/25 14:50 == 48.1	10/14/25 19:20 == 47.9	10/14/25 23:50 == 47.9	10/15/25 4:20 == 48
10/14/25 14:55 == 47.8	10/14/25 19:25 == 48	10/14/25 23:55 == 47.9	10/15/25 4:25 == 48
10/14/25 15:00 == 48.1	10/14/25 19:30 == 48.1	10/15/25 0:00 == 48	10/15/25 4:30 == 48
10/14/25 15:05 == 47.9	10/14/25 19:35 == 48	10/15/25 0:05 == 48.1	10/15/25 4:35 == 48
10/14/25 15:10 == 48	10/14/25 19:40 == 48	10/15/25 0:10 == 48	10/15/25 4:40 == 47.9
10/14/25 15:15 == 48.1	10/14/25 19:45 == 48	10/15/25 0:15 == 48	10/15/25 4:45 == 48
10/14/25 15:20 == 48	10/14/25 19:50 == 48	10/15/25 0:20 == 48	10/15/25 4:50 == 47.9
10/14/25 15:25 == 48	10/14/25 19:55 == 47.9	10/15/25 0:25 == 48	10/15/25 4:55 == 48
10/14/25 15:30 == 48	10/14/25 20:00 == 47.4	10/15/25 0:30 == 48	10/15/25 5:00 == 48
10/14/25 15:35 == 48	10/14/25 20:05 == 47.9	10/15/25 0:35 == 47.9	10/15/25 5:05 == 47.9
10/14/25 15:40 == 47.9	10/14/25 20:10 == 47.2	10/15/25 0:40 == 47.9	10/15/25 5:10 == 48
10/14/25 15:45 == 48	10/14/25 20:15 == 48	10/15/25 0:45 == 48	10/15/25 5:15 == 48
10/14/25 15:50 == 47.9	10/14/25 20:20 == 48	10/15/25 0:50 == 48	10/15/25 5:20 == 47.9
10/14/25 15:55 == 47.5	10/14/25 20:25 == 47.5	10/15/25 0:55 == 48	10/15/25 5:25 == 48
10/14/25 16:00 == 47.8	10/14/25 20:30 == 47.9	10/15/25 1:00 == 48.2	10/15/25 5:30 == 48
10/14/25 16:05 == 47.9	10/14/25 20:35 == 48	10/15/25 1:05 == 47.9	10/15/25 5:35 == 47.9
10/14/25 16:10 == 48.1	10/14/25 20:40 == 47.9	10/15/25 1:10 == 47.3	10/15/25 5:40 == 47.9
10/14/25 16:15 == 48.1	10/14/25 20:45 == 48	10/15/25 1:15 == 48	10/15/25 5:45 == 48.1
10/14/25 16:20 == 48	10/14/25 20:50 == 47.9	10/15/25 1:20 == 47.8	10/15/25 5:50 == 48
10/14/25 16:25 == 47.9	10/14/25 20:55 == 47.5	10/15/25 1:25 == 47.8	10/15/25 5:55 == 47.9

Pumpback Station Discharge (0364)

10/15/25 6:00 == 47.9	10/15/25 10:30 == 47.7	10/15/25 15:00 == 47.9	10/15/25 19:30 == 48
10/15/25 6:05 == 47.9	10/15/25 10:35 == 47.6	10/15/25 15:05 == 47.9	10/15/25 19:35 == 48
10/15/25 6:10 == 47.9	10/15/25 10:40 == 47.7	10/15/25 15:10 == 47.5	10/15/25 19:40 == 48
10/15/25 6:15 == 48	10/15/25 10:45 == 47.7	10/15/25 15:15 == 47.8	10/15/25 19:45 == 48
10/15/25 6:20 == 48.1	10/15/25 10:50 == 47.8	10/15/25 15:20 == 48	10/15/25 19:50 == 48.1
10/15/25 6:25 == 47.9	10/15/25 10:55 == 47.5	10/15/25 15:25 == 48	10/15/25 19:55 == 47.9
10/15/25 6:30 == 47.9	10/15/25 11:00 == 47.8	10/15/25 15:30 == 48	10/15/25 20:00 == 47.9
10/15/25 6:35 == 47.9	10/15/25 11:05 == 48	10/15/25 15:35 == 48	10/15/25 20:05 == 48.1
10/15/25 6:40 == 48	10/15/25 11:10 == 48.1	10/15/25 15:40 == 48.1	10/15/25 20:10 == 47.5
10/15/25 6:45 == 48	10/15/25 11:15 == 48	10/15/25 15:45 == 48	10/15/25 20:15 == 47.9
10/15/25 6:50 == 48	10/15/25 11:20 == 47.8	10/15/25 15:50 == 47.8	10/15/25 20:20 == 48.1
10/15/25 6:55 == 47.3	10/15/25 11:25 == 47.9	10/15/25 15:55 == 47.6	10/15/25 20:25 == 47.6
10/15/25 7:00 == 47.7	10/15/25 11:30 == 48	10/15/25 16:00 == 47.9	10/15/25 20:30 == 47.8
10/15/25 7:05 == 47.9	10/15/25 11:35 == 48	10/15/25 16:05 == 47.9	10/15/25 20:35 == 48
10/15/25 7:10 == 47.7	10/15/25 11:40 == 48	10/15/25 16:10 == 47.7	10/15/25 20:40 == 48
10/15/25 7:15 == 47.9	10/15/25 11:45 == 48	10/15/25 16:15 == 47.9	10/15/25 20:45 == 48
10/15/25 7:20 == 48.1	10/15/25 11:50 == 48.1	10/15/25 16:20 == 47.9	10/15/25 20:50 == 48
10/15/25 7:25 == 48	10/15/25 11:55 == 47.4	10/15/25 16:25 == 48	10/15/25 20:55 == 48
10/15/25 7:30 == 48	10/15/25 12:00 == 47.4	10/15/25 16:30 == 48	10/15/25 21:00 == 48
10/15/25 7:35 == 47.9	10/15/25 12:05 == 47.8	10/15/25 16:35 == 47.9	10/15/25 21:05 == 47.9
10/15/25 7:40 == 48	10/15/25 12:10 == 47.6	10/15/25 16:40 == 48.1	10/15/25 21:10 == 47.8
10/15/25 7:45 == 48.1	10/15/25 12:15 == 47.9	10/15/25 16:45 == 47.9	10/15/25 21:15 == 47.7
10/15/25 7:50 == 48	10/15/25 12:20 == 48	10/15/25 16:50 == 48	10/15/25 21:20 == 47.5
10/15/25 7:55 == 47.7	10/15/25 12:25 == 48	10/15/25 16:55 == 48.1	10/15/25 21:25 == 47.4
10/15/25 8:00 == 47.7	10/15/25 12:30 == 48.2	10/15/25 17:00 == 47.9	10/15/25 21:30 == 48
10/15/25 8:05 == 47.9	10/15/25 12:35 == 48.1	10/15/25 17:05 == 47.7	10/15/25 21:35 == 48.2
10/15/25 8:10 == 47.9	10/15/25 12:40 == 47.9	10/15/25 17:10 == 47.7	10/15/25 21:40 == 48
10/15/25 8:15 == 48	10/15/25 12:45 == 48	10/15/25 17:15 == 47.9	10/15/25 21:45 == 48.1
10/15/25 8:20 == 47.9	10/15/25 12:50 == 48	10/15/25 17:20 == 48.1	10/15/25 21:50 == 47.9
10/15/25 8:25 == 48	10/15/25 12:55 == 48	10/15/25 17:25 == 47.5	10/15/25 21:55 == 48
10/15/25 8:30 == 48	10/15/25 13:00 == 48.1	10/15/25 17:30 == 48	10/15/25 22:00 == 48.1
10/15/25 8:35 == 48.2	10/15/25 13:05 == 47.9	10/15/25 17:35 == 48.1	10/15/25 22:05 == 48
10/15/25 8:40 == 48.1	10/15/25 13:10 == 47.9	10/15/25 17:40 == 47.9	10/15/25 22:10 == 48
10/15/25 8:45 == 48	10/15/25 13:15 == 48	10/15/25 17:45 == 47.9	10/15/25 22:15 == 47.9
10/15/25 8:50 == 48.1	10/15/25 13:20 == 48	10/15/25 17:50 == 48	10/15/25 22:20 == 47.9
10/15/25 8:55 == 47.9	10/15/25 13:25 == 47.8	10/15/25 17:55 == 47.9	10/15/25 22:25 == 47.8
10/15/25 9:00 == 48	10/15/25 13:30 == 47.6	10/15/25 18:00 == 47.9	10/15/25 22:30 == 48
10/15/25 9:05 == 47.8	10/15/25 13:35 == 48	10/15/25 18:05 == 48	10/15/25 22:35 == 48
10/15/25 9:10 == 48.1	10/15/25 13:40 == 48.1	10/15/25 18:10 == 48	10/15/25 22:40 == 47.6
10/15/25 9:15 == 47.9	10/15/25 13:45 == 48.1	10/15/25 18:15 == 48	10/15/25 22:45 == 47.7
10/15/25 9:20 == 48	10/15/25 13:50 == 47.9	10/15/25 18:20 == 48.1	10/15/25 22:50 == 48
10/15/25 9:25 == 48.1	10/15/25 13:55 == 48.1	10/15/25 18:25 == 48	10/15/25 22:55 == 48.1
10/15/25 9:30 == 48	10/15/25 14:00 == 48.1	10/15/25 18:30 == 47.8	10/15/25 23:00 == 48.1
10/15/25 9:35 == 48	10/15/25 14:05 == 48	10/15/25 18:35 == 47.9	10/15/25 23:05 == 48.1
10/15/25 9:40 == 47.9	10/15/25 14:10 == 47.9	10/15/25 18:40 == 48.1	10/15/25 23:10 == 48.2
10/15/25 9:45 == 48	10/15/25 14:15 == 48	10/15/25 18:45 == 48.1	10/15/25 23:15 == 48
10/15/25 9:50 == 48	10/15/25 14:20 == 47.9	10/15/25 18:50 == 48	10/15/25 23:20 == 47.9
10/15/25 9:55 == 47.9	10/15/25 14:25 == 48.3	10/15/25 18:55 == 47.9	10/15/25 23:25 == 48
10/15/25 10:00 == 47.9	10/15/25 14:30 == 48.1	10/15/25 19:00 == 48.1	10/15/25 23:30 == 48
10/15/25 10:05 == 47.9	10/15/25 14:35 == 48	10/15/25 19:05 == 47.8	10/15/25 23:35 == 48
10/15/25 10:10 == 47.5	10/15/25 14:40 == 47.9	10/15/25 19:10 == 48	10/15/25 23:40 == 47.9
10/15/25 10:15 == 47.8	10/15/25 14:45 == 48	10/15/25 19:15 == 48	10/15/25 23:45 == 48
10/15/25 10:20 == 48.1	10/15/25 14:50 == 48	10/15/25 19:20 == 47.9	10/15/25 23:50 == 48.1
10/15/25 10:25 == 48.1	10/15/25 14:55 == 48	10/15/25 19:25 == 48	10/15/25 23:55 == 48

Pumpback Station Discharge (0364)

10/16/25 0:00 == 48.1	10/16/25 4:30 == 48	10/16/25 9:00 == 48	10/16/25 13:30 == 47.9
10/16/25 0:05 == 48.1	10/16/25 4:35 == 47.9	10/16/25 9:05 == 48.1	10/16/25 13:35 == 47.8
10/16/25 0:10 == 48	10/16/25 4:40 == 47.9	10/16/25 9:10 == 47.8	10/16/25 13:40 == 48
10/16/25 0:15 == 47.9	10/16/25 4:45 == 47.8	10/16/25 9:15 == 47.8	10/16/25 13:45 == 48.2
10/16/25 0:20 == 48	10/16/25 4:50 == 47.8	10/16/25 9:20 == 48.2	10/16/25 13:50 == 47.9
10/16/25 0:25 == 47.6	10/16/25 4:55 == 47.6	10/16/25 9:25 == 47.5	10/16/25 13:55 == 47.9
10/16/25 0:30 == 48	10/16/25 5:00 == 47.8	10/16/25 9:30 == 47.5	10/16/25 14:00 == 48.2
10/16/25 0:35 == 47.9	10/16/25 5:05 == 48	10/16/25 9:35 == 48.1	10/16/25 14:05 == 48.1
10/16/25 0:40 == 47.9	10/16/25 5:10 == 48.2	10/16/25 9:40 == 48	10/16/25 14:10 == 47.6
10/16/25 0:45 == 47.8	10/16/25 5:15 == 48.2	10/16/25 9:45 == 47.9	10/16/25 14:15 == 47.8
10/16/25 0:50 == 47.8	10/16/25 5:20 == 48	10/16/25 9:50 == 47.9	10/16/25 14:20 == 48
10/16/25 0:55 == 48	10/16/25 5:25 == 47.9	10/16/25 9:55 == 48	10/16/25 14:25 == 48
10/16/25 1:00 == 48	10/16/25 5:30 == 48.2	10/16/25 10:00 == 48	10/16/25 14:30 == 48
10/16/25 1:05 == 48.1	10/16/25 5:35 == 48	10/16/25 10:05 == 48	10/16/25 14:35 == 47.9
10/16/25 1:10 == 48	10/16/25 5:40 == 47.8	10/16/25 10:10 == 48.1	10/16/25 14:40 == 48
10/16/25 1:15 == 48.1	10/16/25 5:45 == 47.9	10/16/25 10:15 == 48	10/16/25 14:45 == 48
10/16/25 1:20 == 47.9	10/16/25 5:50 == 47.9	10/16/25 10:20 == 47.8	10/16/25 14:50 == 48
10/16/25 1:25 == 48.1	10/16/25 5:55 == 48.1	10/16/25 10:25 == 47.4	10/16/25 14:55 == 48
10/16/25 1:30 == 47.6	10/16/25 6:00 == 47.9	10/16/25 10:30 == 47.9	10/16/25 15:00 == 47.6
10/16/25 1:35 == 47.9	10/16/25 6:05 == 47.9	10/16/25 10:35 == 48.1	10/16/25 15:05 == 47.5
10/16/25 1:40 == 48.1	10/16/25 6:10 == 47.5	10/16/25 10:40 == 48.1	10/16/25 15:10 == 47.9
10/16/25 1:45 == 48	10/16/25 6:15 == 48.1	10/16/25 10:45 == 47.3	10/16/25 15:15 == 48
10/16/25 1:50 == 48	10/16/25 6:20 == 48.1	10/16/25 10:50 == 48	10/16/25 15:20 == 48
10/16/25 1:55 == 48	10/16/25 6:25 == 48	10/16/25 10:55 == 48.2	10/16/25 15:25 == 48
10/16/25 2:00 == 48	10/16/25 6:30 == 47.9	10/16/25 11:00 == 48	10/16/25 15:30 == 47.8
10/16/25 2:05 == 47.6	10/16/25 6:35 == 47.9	10/16/25 11:05 == 48	10/16/25 15:35 == 47.9
10/16/25 2:10 == 47.5	10/16/25 6:40 == 48	10/16/25 11:10 == 47.9	10/16/25 15:40 == 47.9
10/16/25 2:15 == 48.1	10/16/25 6:45 == 48.2	10/16/25 11:15 == 47.9	10/16/25 15:45 == 47.9
10/16/25 2:20 == 47.8	10/16/25 6:50 == 48.1	10/16/25 11:20 == 48.1	10/16/25 15:50 == 48
10/16/25 2:25 == 47.6	10/16/25 6:55 == 47.6	10/16/25 11:25 == 47.7	10/16/25 15:55 == 47.4
10/16/25 2:30 == 47.8	10/16/25 7:00 == 47.7	10/16/25 11:30 == 48	10/16/25 16:00 == 47.2
10/16/25 2:35 == 48.1	10/16/25 7:05 == 47.9	10/16/25 11:35 == 47.9	10/16/25 16:05 == 48
10/16/25 2:40 == 48	10/16/25 7:10 == 47.7	10/16/25 11:40 == 48	10/16/25 16:10 == 47.9
10/16/25 2:45 == 47.9	10/16/25 7:15 == 47.7	10/16/25 11:45 == 48.1	10/16/25 16:15 == 48.1
10/16/25 2:50 == 48	10/16/25 7:20 == 48	10/16/25 11:50 == 48.2	10/16/25 16:20 == 47.9
10/16/25 2:55 == 48	10/16/25 7:25 == 48	10/16/25 11:55 == 47.4	10/16/25 16:25 == 48
10/16/25 3:00 == 48.1	10/16/25 7:30 == 48	10/16/25 12:00 == 47.5	10/16/25 16:30 == 47.9
10/16/25 3:05 == 48	10/16/25 7:35 == 48.1	10/16/25 12:05 == 48	10/16/25 16:35 == 47.9
10/16/25 3:10 == 48	10/16/25 7:40 == 48	10/16/25 12:10 == 47.8	10/16/25 16:40 == 48.1
10/16/25 3:15 == 47.9	10/16/25 7:45 == 48	10/16/25 12:15 == 47.6	10/16/25 16:45 == 48
10/16/25 3:20 == 48	10/16/25 7:50 == 48.1	10/16/25 12:20 == 47.9	10/16/25 16:50 == 48
10/16/25 3:25 == 48.1	10/16/25 7:55 == 48.1	10/16/25 12:25 == 47.7	10/16/25 16:55 == 47.4
10/16/25 3:30 == 48	10/16/25 8:00 == 48	10/16/25 12:30 == 47.7	10/16/25 17:00 == 47.7
10/16/25 3:35 == 48.2	10/16/25 8:05 == 48	10/16/25 12:35 == 48.1	10/16/25 17:05 == 47.6
10/16/25 3:40 == 47.4	10/16/25 8:10 == 47.7	10/16/25 12:40 == 47.9	10/16/25 17:10 == 47.7
10/16/25 3:45 == 47.8	10/16/25 8:15 == 47.6	10/16/25 12:45 == 47.5	10/16/25 17:15 == 48
10/16/25 3:50 == 48	10/16/25 8:20 == 47.2	10/16/25 12:50 == 47.5	10/16/25 17:20 == 47.9
10/16/25 3:55 == 48	10/16/25 8:25 == 47.8	10/16/25 12:55 == 48	10/16/25 17:25 == 47.7
10/16/25 4:00 == 47.9	10/16/25 8:30 == 48.1	10/16/25 13:00 == 48.1	10/16/25 17:30 == 47.7
10/16/25 4:05 == 48.1	10/16/25 8:35 == 48	10/16/25 13:05 == 48	10/16/25 17:35 == 48
10/16/25 4:10 == 48	10/16/25 8:40 == 47.9	10/16/25 13:10 == 47.9	10/16/25 17:40 == 47.9
10/16/25 4:15 == 48	10/16/25 8:45 == 48.1	10/16/25 13:15 == 48	10/16/25 17:45 == 47.9
10/16/25 4:20 == 48	10/16/25 8:50 == 48.1	10/16/25 13:20 == 47.9	10/16/25 17:50 == 48
10/16/25 4:25 == 48.1	10/16/25 8:55 == 48	10/16/25 13:25 == 48.1	10/16/25 17:55 == 48

Pumpback Station Discharge (0364)

10/16/25 18:00 == 48	10/16/25 22:30 == 48	10/17/25 3:00 == 47.9	10/17/25 7:30 == 48.3
10/16/25 18:05 == 48.1	10/16/25 22:35 == 48	10/17/25 3:05 == 48	10/17/25 7:35 == 48
10/16/25 18:10 == 48.1	10/16/25 22:40 == 48	10/17/25 3:10 == 48	10/17/25 7:40 == 48.2
10/16/25 18:15 == 47.4	10/16/25 22:45 == 47.9	10/17/25 3:15 == 48.1	10/17/25 7:45 == 47.9
10/16/25 18:20 == 47.9	10/16/25 22:50 == 48	10/17/25 3:20 == 48.1	10/17/25 7:50 == 48
10/16/25 18:25 == 47.9	10/16/25 22:55 == 48	10/17/25 3:25 == 47.7	10/17/25 7:55 == 47.9
10/16/25 18:30 == 47.9	10/16/25 23:00 == 48	10/17/25 3:30 == 47.8	10/17/25 8:00 == 48
10/16/25 18:35 == 48	10/16/25 23:05 == 48.1	10/17/25 3:35 == 47.8	10/17/25 8:05 == 47.9
10/16/25 18:40 == 48	10/16/25 23:10 == 48	10/17/25 3:40 == 47.6	10/17/25 8:10 == 47.9
10/16/25 18:45 == 48	10/16/25 23:15 == 48	10/17/25 3:45 == 47.8	10/17/25 8:15 == 48.1
10/16/25 18:50 == 48	10/16/25 23:20 == 47.9	10/17/25 3:50 == 48	10/17/25 8:20 == 48
10/16/25 18:55 == 48	10/16/25 23:25 == 47.8	10/17/25 3:55 == 47.9	10/17/25 8:25 == 48.1
10/16/25 19:00 == 48	10/16/25 23:30 == 48.1	10/17/25 4:00 == 48	10/17/25 8:30 == 48.1
10/16/25 19:05 == 48	10/16/25 23:35 == 48	10/17/25 4:05 == 48	10/17/25 8:35 == 48.1
10/16/25 19:10 == 48	10/16/25 23:40 == 48.1	10/17/25 4:10 == 48	10/17/25 8:40 == 48
10/16/25 19:15 == 47.9	10/16/25 23:45 == 48.1	10/17/25 4:15 == 48	10/17/25 8:45 == 48
10/16/25 19:20 == 48	10/16/25 23:50 == 48.1	10/17/25 4:20 == 48	10/17/25 8:50 == 48.1
10/16/25 19:25 == 48	10/16/25 23:55 == 48.1	10/17/25 4:25 == 48.1	10/17/25 8:55 == 48
10/16/25 19:30 == 48.1	10/17/25 0:00 == 47.8	10/17/25 4:30 == 48.1	10/17/25 9:00 == 48.1
10/16/25 19:35 == 48	10/17/25 0:05 == 47.9	10/17/25 4:35 == 48.1	10/17/25 9:05 == 48
10/16/25 19:40 == 47.9	10/17/25 0:10 == 47.9	10/17/25 4:40 == 48	10/17/25 9:10 == 47.7
10/16/25 19:45 == 48.1	10/17/25 0:15 == 48.1	10/17/25 4:45 == 47.9	10/17/25 9:15 == 47.5
10/16/25 19:50 == 48.1	10/17/25 0:20 == 48.1	10/17/25 4:50 == 47.9	10/17/25 9:20 == 47.7
10/16/25 19:55 == 47.6	10/17/25 0:25 == 48.1	10/17/25 4:55 == 47.6	10/17/25 9:25 == 48.1
10/16/25 20:00 == 47.7	10/17/25 0:30 == 47.9	10/17/25 5:00 == 47.8	10/17/25 9:30 == 48.1
10/16/25 20:05 == 47.9	10/17/25 0:35 == 47.9	10/17/25 5:05 == 47.9	10/17/25 9:35 == 48
10/16/25 20:10 == 47.7	10/17/25 0:40 == 47.8	10/17/25 5:10 == 48	10/17/25 9:40 == 48
10/16/25 20:15 == 47.7	10/17/25 0:45 == 47.9	10/17/25 5:15 == 47.9	10/17/25 9:45 == 48
10/16/25 20:20 == 47.8	10/17/25 0:50 == 48	10/17/25 5:20 == 48	10/17/25 9:50 == 47.9
10/16/25 20:25 == 47.6	10/17/25 0:55 == 47.9	10/17/25 5:25 == 47.9	10/17/25 9:55 == 47.9
10/16/25 20:30 == 47.8	10/17/25 1:00 == 47.9	10/17/25 5:30 == 48.1	10/17/25 10:00 == 48
10/16/25 20:35 == 47.9	10/17/25 1:05 == 47.9	10/17/25 5:35 == 48	10/17/25 10:05 == 48
10/16/25 20:40 == 47.9	10/17/25 1:10 == 47.7	10/17/25 5:40 == 48	10/17/25 10:10 == 47.8
10/16/25 20:45 == 48.1	10/17/25 1:15 == 47.8	10/17/25 5:45 == 47.9	10/17/25 10:15 == 47.9
10/16/25 20:50 == 48	10/17/25 1:20 == 48	10/17/25 5:50 == 47.9	10/17/25 10:20 == 48.1
10/16/25 20:55 == 48.1	10/17/25 1:25 == 48	10/17/25 5:55 == 47.8	10/17/25 10:25 == 48.1
10/16/25 21:00 == 47.9	10/17/25 1:30 == 47.9	10/17/25 6:00 == 48	10/17/25 10:30 == 48.1
10/16/25 21:05 == 48	10/17/25 1:35 == 47.8	10/17/25 6:05 == 48	10/17/25 10:35 == 48.1
10/16/25 21:10 == 48	10/17/25 1:40 == 47.9	10/17/25 6:10 == 47.6	10/17/25 10:40 == 47.5
10/16/25 21:15 == 47.9	10/17/25 1:45 == 47.8	10/17/25 6:15 == 47.6	10/17/25 10:45 == 47.8
10/16/25 21:20 == 48	10/17/25 1:50 == 48	10/17/25 6:20 == 48	10/17/25 10:50 == 48.1
10/16/25 21:25 == 47.3	10/17/25 1:55 == 48	10/17/25 6:25 == 48	10/17/25 10:55 == 47.6
10/16/25 21:30 == 48	10/17/25 2:00 == 48	10/17/25 6:30 == 48.1	10/17/25 11:00 == 47.8
10/16/25 21:35 == 48	10/17/25 2:05 == 48.2	10/17/25 6:35 == 48	10/17/25 11:05 == 48
10/16/25 21:40 == 48.1	10/17/25 2:10 == 47.7	10/17/25 6:40 == 48	10/17/25 11:10 == 48
10/16/25 21:45 == 48	10/17/25 2:15 == 48.1	10/17/25 6:45 == 48	10/17/25 11:15 == 48
10/16/25 21:50 == 48	10/17/25 2:20 == 48	10/17/25 6:50 == 47.8	10/17/25 11:20 == 48.1
10/16/25 21:55 == 47.9	10/17/25 2:25 == 47.4	10/17/25 6:55 == 47.5	10/17/25 11:25 == 48.1
10/16/25 22:00 == 48	10/17/25 2:30 == 48.1	10/17/25 7:00 == 48	10/17/25 11:30 == 48
10/16/25 22:05 == 48	10/17/25 2:35 == 48.1	10/17/25 7:05 == 47.9	10/17/25 11:35 == 48
10/16/25 22:10 == 48.1	10/17/25 2:40 == 48	10/17/25 7:10 == 47.4	10/17/25 11:40 == 48
10/16/25 22:15 == 47.9	10/17/25 2:45 == 47.9	10/17/25 7:15 == 48	10/17/25 11:45 == 47.9
10/16/25 22:20 == 47.9	10/17/25 2:50 == 47.9	10/17/25 7:20 == 48.1	10/17/25 11:50 == 47.9
10/16/25 22:25 == 48	10/17/25 2:55 == 48	10/17/25 7:25 == 48	10/17/25 11:55 == 47.6

Pumpback Station Discharge (0364)

10/17/25 12:00 == 47.6	10/17/25 16:30 == 48	10/17/25 21:00 == 47.8	10/18/25 1:30 == 47.9
10/17/25 12:05 == 48.1	10/17/25 16:35 == 47.9	10/17/25 21:05 == 48.1	10/18/25 1:35 == 48.1
10/17/25 12:10 == 48	10/17/25 16:40 == 48	10/17/25 21:10 == 48.2	10/18/25 1:40 == 48
10/17/25 12:15 == 48	10/17/25 16:45 == 48.1	10/17/25 21:15 == 48	10/18/25 1:45 == 48.1
10/17/25 12:20 == 48.1	10/17/25 16:50 == 48.1	10/17/25 21:20 == 48	10/18/25 1:50 == 47.9
10/17/25 12:25 == 48	10/17/25 16:55 == 48	10/17/25 21:25 == 47.5	10/18/25 1:55 == 48
10/17/25 12:30 == 48	10/17/25 17:00 == 48	10/17/25 21:30 == 47.6	10/18/25 2:00 == 47.9
10/17/25 12:35 == 48.1	10/17/25 17:05 == 48	10/17/25 21:35 == 48	10/18/25 2:05 == 47.7
10/17/25 12:40 == 47.8	10/17/25 17:10 == 47.9	10/17/25 21:40 == 48	10/18/25 2:10 == 47.8
10/17/25 12:45 == 48	10/17/25 17:15 == 47.9	10/17/25 21:45 == 48	10/18/25 2:15 == 48
10/17/25 12:50 == 47.9	10/17/25 17:20 == 48	10/17/25 21:50 == 48.1	10/18/25 2:20 == 48.2
10/17/25 12:55 == 47.3	10/17/25 17:25 == 47.3	10/17/25 21:55 == 48.1	10/18/25 2:25 == 47.6
10/17/25 13:00 == 47.9	10/17/25 17:30 == 47.9	10/17/25 22:00 == 48	10/18/25 2:30 == 47.7
10/17/25 13:05 == 48	10/17/25 17:35 == 48	10/17/25 22:05 == 48	10/18/25 2:35 == 48
10/17/25 13:10 == 47.7	10/17/25 17:40 == 47.9	10/17/25 22:10 == 48	10/18/25 2:40 == 48
10/17/25 13:15 == 48.1	10/17/25 17:45 == 48.1	10/17/25 22:15 == 48	10/18/25 2:45 == 48
10/17/25 13:20 == 48.1	10/17/25 17:50 == 48	10/17/25 22:20 == 47.9	10/18/25 2:50 == 48
10/17/25 13:25 == 48	10/17/25 17:55 == 47.6	10/17/25 22:25 == 47.5	10/18/25 2:55 == 47.9
10/17/25 13:30 == 47.9	10/17/25 18:00 == 47.5	10/17/25 22:30 == 48	10/18/25 3:00 == 48
10/17/25 13:35 == 47.9	10/17/25 18:05 == 47.8	10/17/25 22:35 == 48	10/18/25 3:05 == 48.1
10/17/25 13:40 == 47.9	10/17/25 18:10 == 47.9	10/17/25 22:40 == 48.2	10/18/25 3:10 == 48
10/17/25 13:45 == 48	10/17/25 18:15 == 47.5	10/17/25 22:45 == 47.9	10/18/25 3:15 == 48.1
10/17/25 13:50 == 48	10/17/25 18:20 == 47.9	10/17/25 22:50 == 47.9	10/18/25 3:20 == 48.2
10/17/25 13:55 == 48	10/17/25 18:25 == 47.5	10/17/25 22:55 == 48.1	10/18/25 3:25 == 48
10/17/25 14:00 == 48	10/17/25 18:30 == 47.7	10/17/25 23:00 == 47.8	10/18/25 3:30 == 48
10/17/25 14:05 == 48	10/17/25 18:35 == 47.9	10/17/25 23:05 == 48.1	10/18/25 3:35 == 47.8
10/17/25 14:10 == 48	10/17/25 18:40 == 47.5	10/17/25 23:10 == 47.9	10/18/25 3:40 == 47.3
10/17/25 14:15 == 48	10/17/25 18:45 == 47.6	10/17/25 23:15 == 47.9	10/18/25 3:45 == 47.9
10/17/25 14:20 == 47.9	10/17/25 18:50 == 47.9	10/17/25 23:20 == 48	10/18/25 3:50 == 47.3
10/17/25 14:25 == 47.7	10/17/25 18:55 == 48	10/17/25 23:25 == 47.9	10/18/25 3:55 == 47.7
10/17/25 14:30 == 47.7	10/17/25 19:00 == 48.1	10/17/25 23:30 == 47.9	10/18/25 4:00 == 47.9
10/17/25 14:35 == 47.7	10/17/25 19:05 == 48	10/17/25 23:35 == 48.1	10/18/25 4:05 == 48.2
10/17/25 14:40 == 47.9	10/17/25 19:10 == 47.7	10/17/25 23:40 == 48.1	10/18/25 4:10 == 48.1
10/17/25 14:45 == 47.8	10/17/25 19:15 == 47.5	10/17/25 23:45 == 48	10/18/25 4:15 == 47.5
10/17/25 14:50 == 48	10/17/25 19:20 == 47.7	10/17/25 23:50 == 48	10/18/25 4:20 == 48.1
10/17/25 14:55 == 48	10/17/25 19:25 == 47.7	10/17/25 23:55 == 48	10/18/25 4:25 == 48
10/17/25 15:00 == 47.8	10/17/25 19:30 == 47.9	10/18/25 0:00 == 48	10/18/25 4:30 == 48
10/17/25 15:05 == 48	10/17/25 19:35 == 48	10/18/25 0:05 == 48.1	10/18/25 4:35 == 48.1
10/17/25 15:10 == 47.3	10/17/25 19:40 == 47.9	10/18/25 0:10 == 48	10/18/25 4:40 == 47.9
10/17/25 15:15 == 47.3	10/17/25 19:45 == 48	10/18/25 0:15 == 47.8	10/18/25 4:45 == 48
10/17/25 15:20 == 48	10/17/25 19:50 == 48.1	10/18/25 0:20 == 47.9	10/18/25 4:50 == 47.8
10/17/25 15:25 == 48	10/17/25 19:55 == 48.2	10/18/25 0:25 == 48.1	10/18/25 4:55 == 47.8
10/17/25 15:30 == 47.8	10/17/25 20:00 == 47.9	10/18/25 0:30 == 48	10/18/25 5:00 == 48
10/17/25 15:35 == 48.1	10/17/25 20:05 == 47.7	10/18/25 0:35 == 48.1	10/18/25 5:05 == 48.1
10/17/25 15:40 == 48.1	10/17/25 20:10 == 47.4	10/18/25 0:40 == 48	10/18/25 5:10 == 48.1
10/17/25 15:45 == 48.1	10/17/25 20:15 == 48.1	10/18/25 0:45 == 48	10/18/25 5:15 == 48
10/17/25 15:50 == 48.1	10/17/25 20:20 == 48	10/18/25 0:50 == 48.1	10/18/25 5:20 == 48
10/17/25 15:55 == 47.5	10/17/25 20:25 == 47.4	10/18/25 0:55 == 48	10/18/25 5:25 == 47.9
10/17/25 16:00 == 47.9	10/17/25 20:30 == 47.9	10/18/25 1:00 == 48.1	10/18/25 5:30 == 47.9
10/17/25 16:05 == 48	10/17/25 20:35 == 48	10/18/25 1:05 == 47.8	10/18/25 5:35 == 47.9
10/17/25 16:10 == 47.9	10/17/25 20:40 == 48.1	10/18/25 1:10 == 47.5	10/18/25 5:40 == 47.9
10/17/25 16:15 == 48	10/17/25 20:45 == 48	10/18/25 1:15 == 48	10/18/25 5:45 == 47.9
10/17/25 16:20 == 48.1	10/17/25 20:50 == 48.1	10/18/25 1:20 == 48	10/18/25 5:50 == 47.9
10/17/25 16:25 == 48	10/17/25 20:55 == 47.5	10/18/25 1:25 == 47.9	10/18/25 5:55 == 47.9

Pumpback Station Discharge (0364)

10/18/25 6:00 == 48	10/18/25 10:30 == 48.1	10/18/25 15:00 == 47.6	10/18/25 19:30 == 48
10/18/25 6:05 == 47.8	10/18/25 10:35 == 47.9	10/18/25 15:05 == 47.7	10/18/25 19:35 == 48.1
10/18/25 6:10 == 47.4	10/18/25 10:40 == 47.6	10/18/25 15:10 == 47.3	10/18/25 19:40 == 48
10/18/25 6:15 == 47.8	10/18/25 10:45 == 47.7	10/18/25 15:15 == 47.7	10/18/25 19:45 == 47.9
10/18/25 6:20 == 48.2	10/18/25 10:50 == 48	10/18/25 15:20 == 48.1	10/18/25 19:50 == 47.9
10/18/25 6:25 == 48.1	10/18/25 10:55 == 47.7	10/18/25 15:25 == 48.1	10/18/25 19:55 == 47.8
10/18/25 6:30 == 48.1	10/18/25 11:00 == 47.8	10/18/25 15:30 == 48	10/18/25 20:00 == 47.7
10/18/25 6:35 == 48.1	10/18/25 11:05 == 48	10/18/25 15:35 == 48	10/18/25 20:05 == 48.1
10/18/25 6:40 == 47.7	10/18/25 11:10 == 48.1	10/18/25 15:40 == 47.7	10/18/25 20:10 == 47.5
10/18/25 6:45 == 47.6	10/18/25 11:15 == 48.1	10/18/25 15:45 == 47.7	10/18/25 20:15 == 47.8
10/18/25 6:50 == 48	10/18/25 11:20 == 48.1	10/18/25 15:50 == 47.8	10/18/25 20:20 == 48
10/18/25 6:55 == 47.3	10/18/25 11:25 == 47.8	10/18/25 15:55 == 47.5	10/18/25 20:25 == 47.5
10/18/25 7:00 == 47.8	10/18/25 11:30 == 47.5	10/18/25 16:00 == 47.9	10/18/25 20:30 == 47.8
10/18/25 7:05 == 48	10/18/25 11:35 == 47.8	10/18/25 16:05 == 48.1	10/18/25 20:35 == 48.1
10/18/25 7:10 == 47.5	10/18/25 11:40 == 47.9	10/18/25 16:10 == 48	10/18/25 20:40 == 47.9
10/18/25 7:15 == 47.8	10/18/25 11:45 == 48	10/18/25 16:15 == 48.2	10/18/25 20:45 == 47.9
10/18/25 7:20 == 48	10/18/25 11:50 == 48.1	10/18/25 16:20 == 48.2	10/18/25 20:50 == 47.9
10/18/25 7:25 == 48	10/18/25 11:55 == 47.5	10/18/25 16:25 == 48.1	10/18/25 20:55 == 47.9
10/18/25 7:30 == 47.9	10/18/25 12:00 == 47.4	10/18/25 16:30 == 48.1	10/18/25 21:00 == 48
10/18/25 7:35 == 47.9	10/18/25 12:05 == 48	10/18/25 16:35 == 48.1	10/18/25 21:05 == 48
10/18/25 7:40 == 47.9	10/18/25 12:10 == 47.4	10/18/25 16:40 == 47.9	10/18/25 21:10 == 47.8
10/18/25 7:45 == 48	10/18/25 12:15 == 47.8	10/18/25 16:45 == 48.1	10/18/25 21:15 == 47.6
10/18/25 7:50 == 48	10/18/25 12:20 == 47.9	10/18/25 16:50 == 48	10/18/25 21:20 == 47.5
10/18/25 7:55 == 48	10/18/25 12:25 == 47.9	10/18/25 16:55 == 48	10/18/25 21:25 == 47.3
10/18/25 8:00 == 47.9	10/18/25 12:30 == 48	10/18/25 17:00 == 48	10/18/25 21:30 == 47.4
10/18/25 8:05 == 47.9	10/18/25 12:35 == 47.9	10/18/25 17:05 == 47.9	10/18/25 21:35 == 47.9
10/18/25 8:10 == 47.6	10/18/25 12:40 == 47.9	10/18/25 17:10 == 47.5	10/18/25 21:40 == 48
10/18/25 8:15 == 47.6	10/18/25 12:45 == 47.9	10/18/25 17:15 == 47.8	10/18/25 21:45 == 47.9
10/18/25 8:20 == 47.9	10/18/25 12:50 == 48	10/18/25 17:20 == 48	10/18/25 21:50 == 47.9
10/18/25 8:25 == 48.1	10/18/25 12:55 == 48.1	10/18/25 17:25 == 47.4	10/18/25 21:55 == 48
10/18/25 8:30 == 48.2	10/18/25 13:00 == 48	10/18/25 17:30 == 47.9	10/18/25 22:00 == 47.9
10/18/25 8:35 == 48	10/18/25 13:05 == 48	10/18/25 17:35 == 48	10/18/25 22:05 == 47.9
10/18/25 8:40 == 48.1	10/18/25 13:10 == 48	10/18/25 17:40 == 48	10/18/25 22:10 == 48.1
10/18/25 8:45 == 48	10/18/25 13:15 == 48	10/18/25 17:45 == 48.1	10/18/25 22:15 == 48
10/18/25 8:50 == 47.9	10/18/25 13:20 == 47.9	10/18/25 17:50 == 47.9	10/18/25 22:20 == 47.9
10/18/25 8:55 == 48	10/18/25 13:25 == 47.9	10/18/25 17:55 == 47.5	10/18/25 22:25 == 48
10/18/25 9:00 == 47.9	10/18/25 13:30 == 47.9	10/18/25 18:00 == 47.6	10/18/25 22:30 == 48
10/18/25 9:05 == 48	10/18/25 13:35 == 47.8	10/18/25 18:05 == 47.8	10/18/25 22:35 == 47.9
10/18/25 9:10 == 48	10/18/25 13:40 == 47.9	10/18/25 18:10 == 47.9	10/18/25 22:40 == 47.9
10/18/25 9:15 == 48	10/18/25 13:45 == 48	10/18/25 18:15 == 48	10/18/25 22:45 == 48
10/18/25 9:20 == 47.9	10/18/25 13:50 == 47.9	10/18/25 18:20 == 47.8	10/18/25 22:50 == 48.1
10/18/25 9:25 == 48	10/18/25 13:55 == 48	10/18/25 18:25 == 47.8	10/18/25 22:55 == 47.9
10/18/25 9:30 == 48.1	10/18/25 14:00 == 48	10/18/25 18:30 == 47.7	10/18/25 23:00 == 47.7
10/18/25 9:35 == 47.9	10/18/25 14:05 == 48	10/18/25 18:35 == 47.7	10/18/25 23:05 == 47.7
10/18/25 9:40 == 48	10/18/25 14:10 == 48	10/18/25 18:40 == 48.1	10/18/25 23:10 == 48
10/18/25 9:45 == 47.9	10/18/25 14:15 == 48.1	10/18/25 18:45 == 48.1	10/18/25 23:15 == 48.1
10/18/25 9:50 == 48.1	10/18/25 14:20 == 48	10/18/25 18:50 == 48.1	10/18/25 23:20 == 48
10/18/25 9:55 == 48.2	10/18/25 14:25 == 47.9	10/18/25 18:55 == 48	10/18/25 23:25 == 48
10/18/25 10:00 == 48.1	10/18/25 14:30 == 47.9	10/18/25 19:00 == 47.9	10/18/25 23:30 == 48
10/18/25 10:05 == 48	10/18/25 14:35 == 48.1	10/18/25 19:05 == 47.8	10/18/25 23:35 == 48
10/18/25 10:10 == 48	10/18/25 14:40 == 48	10/18/25 19:10 == 48.1	10/18/25 23:40 == 48
10/18/25 10:15 == 48.1	10/18/25 14:45 == 47.5	10/18/25 19:15 == 48.2	10/18/25 23:45 == 47.9
10/18/25 10:20 == 48.1	10/18/25 14:50 == 47.8	10/18/25 19:20 == 48	10/18/25 23:50 == 47.9
10/18/25 10:25 == 48.1	10/18/25 14:55 == 48.1	10/18/25 19:25 == 48.1	10/18/25 23:55 == 47.9

Pumpback Station Discharge (0364)

10/19/25 0:00 == 48	10/19/25 4:30 == 48.1	10/19/25 9:00 == 48	10/19/25 13:30 == 48
10/19/25 0:05 == 48	10/19/25 4:35 == 48.1	10/19/25 9:05 == 48	10/19/25 13:35 == 48.2
10/19/25 0:10 == 47.6	10/19/25 4:40 == 48.1	10/19/25 9:10 == 48	10/19/25 13:40 == 47.9
10/19/25 0:15 == 48.1	10/19/25 4:45 == 48	10/19/25 9:15 == 48	10/19/25 13:45 == 47.9
10/19/25 0:20 == 48.2	10/19/25 4:50 == 47.8	10/19/25 9:20 == 48	10/19/25 13:50 == 48
10/19/25 0:25 == 47.5	10/19/25 4:55 == 47.5	10/19/25 9:25 == 48	10/19/25 13:55 == 48.2
10/19/25 0:30 == 48	10/19/25 5:00 == 48	10/19/25 9:30 == 48	10/19/25 14:00 == 48
10/19/25 0:35 == 48	10/19/25 5:05 == 48	10/19/25 9:35 == 47.9	10/19/25 14:05 == 48
10/19/25 0:40 == 48.1	10/19/25 5:10 == 47.9	10/19/25 9:40 == 48	10/19/25 14:10 == 48
10/19/25 0:45 == 48	10/19/25 5:15 == 47.9	10/19/25 9:45 == 48	10/19/25 14:15 == 48
10/19/25 0:50 == 48	10/19/25 5:20 == 48.1	10/19/25 9:50 == 48	10/19/25 14:20 == 48.1
10/19/25 0:55 == 47.9	10/19/25 5:25 == 48	10/19/25 9:55 == 47.9	10/19/25 14:25 == 48
10/19/25 1:00 == 48	10/19/25 5:30 == 48.1	10/19/25 10:00 == 48	10/19/25 14:30 == 48
10/19/25 1:05 == 48	10/19/25 5:35 == 48	10/19/25 10:05 == 47.9	10/19/25 14:35 == 48
10/19/25 1:10 == 48.1	10/19/25 5:40 == 48	10/19/25 10:10 == 48	10/19/25 14:40 == 48
10/19/25 1:15 == 48.1	10/19/25 5:45 == 48	10/19/25 10:15 == 48	10/19/25 14:45 == 47.8
10/19/25 1:20 == 48	10/19/25 5:50 == 48.1	10/19/25 10:20 == 48	10/19/25 14:50 == 47.9
10/19/25 1:25 == 47.9	10/19/25 5:55 == 48	10/19/25 10:25 == 47.9	10/19/25 14:55 == 48.1
10/19/25 1:30 == 48	10/19/25 6:00 == 48	10/19/25 10:30 == 47.9	10/19/25 15:00 == 48
10/19/25 1:35 == 48.1	10/19/25 6:05 == 48	10/19/25 10:35 == 47.9	10/19/25 15:05 == 47.8
10/19/25 1:40 == 48.1	10/19/25 6:10 == 47.5	10/19/25 10:40 == 47.6	10/19/25 15:10 == 47.5
10/19/25 1:45 == 48.2	10/19/25 6:15 == 47.9	10/19/25 10:45 == 47.9	10/19/25 15:15 == 47.8
10/19/25 1:50 == 48.1	10/19/25 6:20 == 48	10/19/25 10:50 == 48	10/19/25 15:20 == 48
10/19/25 1:55 == 48	10/19/25 6:25 == 48.1	10/19/25 10:55 == 47.4	10/19/25 15:25 == 47.8
10/19/25 2:00 == 48.1	10/19/25 6:30 == 47.9	10/19/25 11:00 == 47.9	10/19/25 15:30 == 48
10/19/25 2:05 == 48.1	10/19/25 6:35 == 48	10/19/25 11:05 == 48	10/19/25 15:35 == 47.9
10/19/25 2:10 == 47.7	10/19/25 6:40 == 48	10/19/25 11:10 == 47.8	10/19/25 15:40 == 47.9
10/19/25 2:15 == 47.6	10/19/25 6:45 == 48	10/19/25 11:15 == 47.8	10/19/25 15:45 == 47.9
10/19/25 2:20 == 47.9	10/19/25 6:50 == 48	10/19/25 11:20 == 47.8	10/19/25 15:50 == 48.1
10/19/25 2:25 == 47.6	10/19/25 6:55 == 47.5	10/19/25 11:25 == 47.9	10/19/25 15:55 == 47.3
10/19/25 2:30 == 47.8	10/19/25 7:00 == 47.5	10/19/25 11:30 == 48	10/19/25 16:00 == 47.8
10/19/25 2:35 == 48	10/19/25 7:05 == 47.8	10/19/25 11:35 == 48.1	10/19/25 16:05 == 48.1
10/19/25 2:40 == 48.1	10/19/25 7:10 == 47.6	10/19/25 11:40 == 48	10/19/25 16:10 == 48
10/19/25 2:45 == 48.1	10/19/25 7:15 == 47.7	10/19/25 11:45 == 47.8	10/19/25 16:15 == 47.8
10/19/25 2:50 == 48	10/19/25 7:20 == 47.9	10/19/25 11:50 == 48	10/19/25 16:20 == 47.9
10/19/25 2:55 == 48.1	10/19/25 7:25 == 47.9	10/19/25 11:55 == 47.2	10/19/25 16:25 == 47.4
10/19/25 3:00 == 48	10/19/25 7:30 == 48.1	10/19/25 12:00 == 47.3	10/19/25 16:30 == 47.7
10/19/25 3:05 == 47.8	10/19/25 7:35 == 48.1	10/19/25 12:05 == 48	10/19/25 16:35 == 47.9
10/19/25 3:10 == 48.2	10/19/25 7:40 == 47.9	10/19/25 12:10 == 47.8	10/19/25 16:40 == 47.9
10/19/25 3:15 == 47.9	10/19/25 7:45 == 47.9	10/19/25 12:15 == 47.7	10/19/25 16:45 == 48
10/19/25 3:20 == 47.9	10/19/25 7:50 == 47.9	10/19/25 12:20 == 48	10/19/25 16:50 == 48
10/19/25 3:25 == 47.8	10/19/25 7:55 == 48	10/19/25 12:25 == 48	10/19/25 16:55 == 47.6
10/19/25 3:30 == 47.4	10/19/25 8:00 == 48	10/19/25 12:30 == 48	10/19/25 17:00 == 47.5
10/19/25 3:35 == 47.8	10/19/25 8:05 == 47.9	10/19/25 12:35 == 48	10/19/25 17:05 == 47.7
10/19/25 3:40 == 47.1	10/19/25 8:10 == 47.9	10/19/25 12:40 == 47.9	10/19/25 17:10 == 47.6
10/19/25 3:45 == 47.9	10/19/25 8:15 == 48.1	10/19/25 12:45 == 48	10/19/25 17:15 == 47.7
10/19/25 3:50 == 48.1	10/19/25 8:20 == 47.9	10/19/25 12:50 == 47.9	10/19/25 17:20 == 47.9
10/19/25 3:55 == 48	10/19/25 8:25 == 47.9	10/19/25 12:55 == 48.1	10/19/25 17:25 == 47.5
10/19/25 4:00 == 47.9	10/19/25 8:30 == 48	10/19/25 13:00 == 48.1	10/19/25 17:30 == 47.6
10/19/25 4:05 == 48	10/19/25 8:35 == 47.9	10/19/25 13:05 == 48	10/19/25 17:35 == 48
10/19/25 4:10 == 48	10/19/25 8:40 == 48	10/19/25 13:10 == 48	10/19/25 17:40 == 47.9
10/19/25 4:15 == 48	10/19/25 8:45 == 47.9	10/19/25 13:15 == 48.1	10/19/25 17:45 == 48
10/19/25 4:20 == 48	10/19/25 8:50 == 48	10/19/25 13:20 == 48	10/19/25 17:50 == 47.8
10/19/25 4:25 == 48	10/19/25 8:55 == 48	10/19/25 13:25 == 47.9	10/19/25 17:55 == 47.8

Pumpback Station Discharge (0364)

10/19/25 18:00 == 48	10/19/25 22:30 == 47.9	10/20/25 3:00 == 48	10/20/25 7:30 == 47.9
10/19/25 18:05 == 48.1	10/19/25 22:35 == 48	10/20/25 3:05 == 48	10/20/25 7:35 == 48
10/19/25 18:10 == 48	10/19/25 22:40 == 48.2	10/20/25 3:10 == 47.9	10/20/25 7:40 == 48.1
10/19/25 18:15 == 48.1	10/19/25 22:45 == 48.1	10/20/25 3:15 == 47.9	10/20/25 7:45 == 48
10/19/25 18:20 == 48	10/19/25 22:50 == 48	10/20/25 3:20 == 48.1	10/20/25 7:50 == 48
10/19/25 18:25 == 47.7	10/19/25 22:55 == 47.7	10/20/25 3:25 == 48.1	10/20/25 7:55 == 47.8
10/19/25 18:30 == 47.3	10/19/25 23:00 == 47.7	10/20/25 3:30 == 48	10/20/25 8:00 == 47.9
10/19/25 18:35 == 48.2	10/19/25 23:05 == 48.1	10/20/25 3:35 == 47.8	10/20/25 8:05 == 48
10/19/25 18:40 == 47.9	10/19/25 23:10 == 48.1	10/20/25 3:40 == 47.2	10/20/25 8:10 == 47.6
10/19/25 18:45 == 47.9	10/19/25 23:15 == 48.1	10/20/25 3:45 == 47.4	10/20/25 8:15 == 47.7
10/19/25 18:50 == 48	10/19/25 23:20 == 48	10/20/25 3:50 == 48.1	10/20/25 8:20 == 47.9
10/19/25 18:55 == 48.1	10/19/25 23:25 == 48	10/20/25 3:55 == 47.9	10/20/25 8:25 == 47.9
10/19/25 19:00 == 48	10/19/25 23:30 == 48	10/20/25 4:00 == 47.9	10/20/25 8:30 == 48
10/19/25 19:05 == 48	10/19/25 23:35 == 48.1	10/20/25 4:05 == 48	10/20/25 8:35 == 47.9
10/19/25 19:10 == 47.9	10/19/25 23:40 == 48	10/20/25 4:10 == 48.2	10/20/25 8:40 == 48
10/19/25 19:15 == 47.9	10/19/25 23:45 == 48	10/20/25 4:15 == 48.1	10/20/25 8:45 == 48.1
10/19/25 19:20 == 48.1	10/19/25 23:50 == 47.8	10/20/25 4:20 == 48	10/20/25 8:50 == 47.8
10/19/25 19:25 == 47.6	10/19/25 23:55 == 48	10/20/25 4:25 == 48	10/20/25 8:55 == 47.8
10/19/25 19:30 == 47.7	10/20/25 0:00 == 47.9	10/20/25 4:30 == 47.7	10/20/25 9:00 == 48
10/19/25 19:35 == 47.9	10/20/25 0:05 == 48.1	10/20/25 4:35 == 48.1	10/20/25 9:05 == 48
10/19/25 19:40 == 48	10/20/25 0:10 == 47.4	10/20/25 4:40 == 47.9	10/20/25 9:10 == 48
10/19/25 19:45 == 48	10/20/25 0:15 == 47.9	10/20/25 4:45 == 48	10/20/25 9:15 == 47.9
10/19/25 19:50 == 48.1	10/20/25 0:20 == 48.1	10/20/25 4:50 == 48	10/20/25 9:20 == 48
10/19/25 19:55 == 48	10/20/25 0:25 == 48.1	10/20/25 4:55 == 47.4	10/20/25 9:25 == 48
10/19/25 20:00 == 47.9	10/20/25 0:30 == 48.1	10/20/25 5:00 == 47.9	10/20/25 9:30 == 47.9
10/19/25 20:05 == 47.8	10/20/25 0:35 == 48	10/20/25 5:05 == 48	10/20/25 9:35 == 48
10/19/25 20:10 == 47.8	10/20/25 0:40 == 48	10/20/25 5:10 == 48	10/20/25 9:40 == 48
10/19/25 20:15 == 47.7	10/20/25 0:45 == 47.9	10/20/25 5:15 == 48.1	10/20/25 9:45 == 48
10/19/25 20:20 == 47.6	10/20/25 0:50 == 47.9	10/20/25 5:20 == 48.1	10/20/25 9:50 == 47.2
10/19/25 20:25 == 47.5	10/20/25 0:55 == 48	10/20/25 5:25 == 48	10/20/25 9:55 == 48
10/19/25 20:30 == 47.9	10/20/25 1:00 == 48	10/20/25 5:30 == 48	10/20/25 10:00 == 47.9
10/19/25 20:35 == 48	10/20/25 1:05 == 48.1	10/20/25 5:35 == 48	10/20/25 10:05 == 47.9
10/19/25 20:40 == 48	10/20/25 1:10 == 48.1	10/20/25 5:40 == 48	10/20/25 10:10 == 48
10/19/25 20:45 == 47.9	10/20/25 1:15 == 48	10/20/25 5:45 == 48.2	10/20/25 10:15 == 48.1
10/19/25 20:50 == 47.9	10/20/25 1:20 == 47.9	10/20/25 5:50 == 48.3	10/20/25 10:20 == 47.9
10/19/25 20:55 == 47.8	10/20/25 1:25 == 47.7	10/20/25 5:55 == 47.9	10/20/25 10:25 == 48
10/19/25 21:00 == 47.5	10/20/25 1:30 == 47.7	10/20/25 6:00 == 47.9	10/20/25 10:30 == 47.9
10/19/25 21:05 == 48.1	10/20/25 1:35 == 47.9	10/20/25 6:05 == 48	10/20/25 10:35 == 48
10/19/25 21:10 == 48	10/20/25 1:40 == 48	10/20/25 6:10 == 47.7	10/20/25 10:40 == 47.5
10/19/25 21:15 == 48.1	10/20/25 1:45 == 47.9	10/20/25 6:15 == 47.7	10/20/25 10:45 == 47.7
10/19/25 21:20 == 48	10/20/25 1:50 == 47.9	10/20/25 6:20 == 48	10/20/25 10:50 == 48
10/19/25 21:25 == 47.4	10/20/25 1:55 == 48.1	10/20/25 6:25 == 48	10/20/25 10:55 == 48
10/19/25 21:30 == 47.9	10/20/25 2:00 == 48.1	10/20/25 6:30 == 47.9	10/20/25 11:00 == 48.1
10/19/25 21:35 == 47.9	10/20/25 2:05 == 48	10/20/25 6:35 == 48	10/20/25 11:05 == 48
10/19/25 21:40 == 48	10/20/25 2:10 == 47.8	10/20/25 6:40 == 48	10/20/25 11:10 == 47.4
10/19/25 21:45 == 47.7	10/20/25 2:15 == 47.5	10/20/25 6:45 == 48	10/20/25 11:15 == 47.5
10/19/25 21:50 == 47.9	10/20/25 2:20 == 48.1	10/20/25 6:50 == 47.9	10/20/25 11:20 == 47.8
10/19/25 21:55 == 47.9	10/20/25 2:25 == 47.3	10/20/25 6:55 == 47.5	10/20/25 11:25 == 47.7
10/19/25 22:00 == 47.8	10/20/25 2:30 == 48.1	10/20/25 7:00 == 47.9	10/20/25 11:30 == 47.9
10/19/25 22:05 == 47.9	10/20/25 2:35 == 48.1	10/20/25 7:05 == 48	10/20/25 11:35 == 48.1
10/19/25 22:10 == 47.9	10/20/25 2:40 == 48	10/20/25 7:10 == 47.3	10/20/25 11:40 == 48.1
10/19/25 22:15 == 47.7	10/20/25 2:45 == 48.1	10/20/25 7:15 == 47.8	10/20/25 11:45 == 48
10/19/25 22:20 == 47.8	10/20/25 2:50 == 48.1	10/20/25 7:20 == 48	10/20/25 11:50 == 47.8
10/19/25 22:25 == 47.9	10/20/25 2:55 == 48	10/20/25 7:25 == 48	10/20/25 11:55 == 47.6

Pumpback Station Discharge (0364)

10/20/25 12:00 == 48.1	10/20/25 16:30 == 48	10/20/25 21:00 == 48.1	10/21/25 1:30 == 48.1
10/20/25 12:05 == 48.1	10/20/25 16:35 == 47.8	10/20/25 21:05 == 47.9	10/21/25 1:35 == 48.1
10/20/25 12:10 == 47.8	10/20/25 16:40 == 47.6	10/20/25 21:10 == 48.1	10/21/25 1:40 == 47.9
10/20/25 12:15 == 47.9	10/20/25 16:45 == 47.7	10/20/25 21:15 == 47.6	10/21/25 1:45 == 47.9
10/20/25 12:20 == 47.8	10/20/25 16:50 == 47.9	10/20/25 21:20 == 47.6	10/21/25 1:50 == 47.6
10/20/25 12:25 == 47.6	10/20/25 16:55 == 48	10/20/25 21:25 == 47.9	10/21/25 1:55 == 47.8
10/20/25 12:30 == 47.8	10/20/25 17:00 == 47.9	10/20/25 21:30 == 48	10/21/25 2:00 == 48
10/20/25 12:35 == 48	10/20/25 17:05 == 47.7	10/20/25 21:35 == 48	10/21/25 2:05 == 47.6
10/20/25 12:40 == 48.1	10/20/25 17:10 == 47.3	10/20/25 21:40 == 48	10/21/25 2:10 == 47.9
10/20/25 12:45 == 47.4	10/20/25 17:15 == 48	10/20/25 21:45 == 48	10/21/25 2:15 == 48
10/20/25 12:50 == 48	10/20/25 17:20 == 47.9	10/20/25 21:50 == 48.1	10/21/25 2:20 == 48.1
10/20/25 12:55 == 47.9	10/20/25 17:25 == 47.5	10/20/25 21:55 == 48	10/21/25 2:25 == 48
10/20/25 13:00 == 48	10/20/25 17:30 == 48	10/20/25 22:00 == 48	10/21/25 2:30 == 47.9
10/20/25 13:05 == 47.9	10/20/25 17:35 == 47.9	10/20/25 22:05 == 48	10/21/25 2:35 == 47.9
10/20/25 13:10 == 47.9	10/20/25 17:40 == 47.9	10/20/25 22:10 == 48.1	10/21/25 2:40 == 48
10/20/25 13:15 == 47.9	10/20/25 17:45 == 48	10/20/25 22:15 == 48.1	10/21/25 2:45 == 48
10/20/25 13:20 == 48.1	10/20/25 17:50 == 48.1	10/20/25 22:20 == 48	10/21/25 2:50 == 47.9
10/20/25 13:25 == 47.7	10/20/25 17:55 == 48	10/20/25 22:25 == 48.2	10/21/25 2:55 == 47.9
10/20/25 13:30 == 47.8	10/20/25 18:00 == 47.9	10/20/25 22:30 == 48	10/21/25 3:00 == 48
10/20/25 13:35 == 47.7	10/20/25 18:05 == 48.2	10/20/25 22:35 == 47.9	10/21/25 3:05 == 48
10/20/25 13:40 == 47.8	10/20/25 18:10 == 48.1	10/20/25 22:40 == 47.9	10/21/25 3:10 == 48.1
10/20/25 13:45 == 48	10/20/25 18:15 == 48.1	10/20/25 22:45 == 48.1	10/21/25 3:15 == 48.1
10/20/25 13:50 == 48	10/20/25 18:20 == 48.1	10/20/25 22:50 == 48.1	10/21/25 3:20 == 47.9
10/20/25 13:55 == 48	10/20/25 18:25 == 48.2	10/20/25 22:55 == 47.9	10/21/25 3:25 == 47.9
10/20/25 14:00 == 47.9	10/20/25 18:30 == 48.1	10/20/25 23:00 == 48	10/21/25 3:30 == 48
10/20/25 14:05 == 47.9	10/20/25 18:35 == 48	10/20/25 23:05 == 48.1	10/21/25 3:35 == 48.1
10/20/25 14:10 == 48	10/20/25 18:40 == 48	10/20/25 23:10 == 47.4	10/21/25 3:40 == 48.1
10/20/25 14:15 == 48	10/20/25 18:45 == 48.1	10/20/25 23:15 == 48	10/21/25 3:45 == 48.1
10/20/25 14:20 == 47.9	10/20/25 18:50 == 48	10/20/25 23:20 == 47.9	10/21/25 3:50 == 48.1
10/20/25 14:25 == 47.9	10/20/25 18:55 == 47.9	10/20/25 23:25 == 47.8	10/21/25 3:55 == 47.3
10/20/25 14:30 == 47.8	10/20/25 19:00 == 47.9	10/20/25 23:30 == 48	10/21/25 4:00 == 47.8
10/20/25 14:35 == 48	10/20/25 19:05 == 48	10/20/25 23:35 == 48	10/21/25 4:05 == 48
10/20/25 14:40 == 48	10/20/25 19:10 == 48	10/20/25 23:40 == 48.1	10/21/25 4:10 == 47.9
10/20/25 14:45 == 47.9	10/20/25 19:15 == 48	10/20/25 23:45 == 48.1	10/21/25 4:15 == 48
10/20/25 14:50 == 48.1	10/20/25 19:20 == 47.9	10/20/25 23:50 == 47.9	10/21/25 4:20 == 47.9
10/20/25 14:55 == 48	10/20/25 19:25 == 47.8	10/20/25 23:55 == 47.9	10/21/25 4:25 == 47.9
10/20/25 15:00 == 48	10/20/25 19:30 == 47.8	10/21/25 0:00 == 48	10/21/25 4:30 == 48
10/20/25 15:05 == 48.2	10/20/25 19:35 == 48	10/21/25 0:05 == 48	10/21/25 4:35 == 48
10/20/25 15:10 == 48.1	10/20/25 19:40 == 48	10/21/25 0:10 == 48	10/21/25 4:40 == 47.9
10/20/25 15:15 == 48	10/20/25 19:45 == 48	10/21/25 0:15 == 48	10/21/25 4:45 == 47.9
10/20/25 15:20 == 48	10/20/25 19:50 == 48	10/21/25 0:20 == 48.1	10/21/25 4:50 == 48.1
10/20/25 15:25 == 48	10/20/25 19:55 == 47.9	10/21/25 0:25 == 48.1	10/21/25 4:55 == 48.1
10/20/25 15:30 == 47.6	10/20/25 20:00 == 48	10/21/25 0:30 == 48	10/21/25 5:00 == 48.1
10/20/25 15:35 == 47.7	10/20/25 20:05 == 48	10/21/25 0:35 == 47.9	10/21/25 5:05 == 48.1
10/20/25 15:40 == 47.3	10/20/25 20:10 == 48.1	10/21/25 0:40 == 47.9	10/21/25 5:10 == 48
10/20/25 15:45 == 47.9	10/20/25 20:15 == 48	10/21/25 0:45 == 47.9	10/21/25 5:15 == 48
10/20/25 15:50 == 48.2	10/20/25 20:20 == 47.9	10/21/25 0:50 == 47.9	10/21/25 5:20 == 48
10/20/25 15:55 == 47.4	10/20/25 20:25 == 48	10/21/25 0:55 == 48	10/21/25 5:25 == 47.9
10/20/25 16:00 == 47.8	10/20/25 20:30 == 48	10/21/25 1:00 == 48.1	10/21/25 5:30 == 47.9
10/20/25 16:05 == 47.9	10/20/25 20:35 == 48	10/21/25 1:05 == 48	10/21/25 5:35 == 48
10/20/25 16:10 == 47.8	10/20/25 20:40 == 47.3	10/21/25 1:10 == 47.9	10/21/25 5:40 == 48
10/20/25 16:15 == 47.5	10/20/25 20:45 == 47.8	10/21/25 1:15 == 47.8	10/21/25 5:45 == 48
10/20/25 16:20 == 47.7	10/20/25 20:50 == 47.9	10/21/25 1:20 == 48.1	10/21/25 5:50 == 48
10/20/25 16:25 == 48	10/20/25 20:55 == 48	10/21/25 1:25 == 48.2	10/21/25 5:55 == 47.9

Pumpback Station Discharge (0364)

10/21/25 6:00 == 48	10/21/25 10:30 == 47.6	10/21/25 15:00 == 48	10/21/25 19:30 == 47.6
10/21/25 6:05 == 47.9	10/21/25 10:35 == 47.5	10/21/25 15:05 == 48	10/21/25 19:35 == 48
10/21/25 6:10 == 48.1	10/21/25 10:40 == 47.4	10/21/25 15:10 == 47.5	10/21/25 19:40 == 48
10/21/25 6:15 == 48	10/21/25 10:45 == 47.7	10/21/25 15:15 == 47.8	10/21/25 19:45 == 47.8
10/21/25 6:20 == 47.9	10/21/25 10:50 == 47.7	10/21/25 15:20 == 48	10/21/25 19:50 == 48
10/21/25 6:25 == 48.1	10/21/25 10:55 == 47.6	10/21/25 15:25 == 47.9	10/21/25 19:55 == 47.6
10/21/25 6:30 == 47.9	10/21/25 11:00 == 47.9	10/21/25 15:30 == 48	10/21/25 20:00 == 47.9
10/21/25 6:35 == 47.9	10/21/25 11:05 == 47.8	10/21/25 15:35 == 47.8	10/21/25 20:05 == 48
10/21/25 6:40 == 47.6	10/21/25 11:10 == 47.7	10/21/25 15:40 == 47.6	10/21/25 20:10 == 47.9
10/21/25 6:45 == 47.8	10/21/25 11:15 == 47.9	10/21/25 15:45 == 47.8	10/21/25 20:15 == 47.8
10/21/25 6:50 == 47.7	10/21/25 11:20 == 47.7	10/21/25 15:50 == 47.7	10/21/25 20:20 == 47.9
10/21/25 6:55 == 48	10/21/25 11:25 == 47.1	10/21/25 15:55 == 47.5	10/21/25 20:25 == 47.7
10/21/25 7:00 == 47.9	10/21/25 11:30 == 47.9	10/21/25 16:00 == 47.9	10/21/25 20:30 == 47.8
10/21/25 7:05 == 48	10/21/25 11:35 == 47.9	10/21/25 16:05 == 48	10/21/25 20:35 == 47.9
10/21/25 7:10 == 47.5	10/21/25 11:40 == 47.6	10/21/25 16:10 == 47.8	10/21/25 20:40 == 47.7
10/21/25 7:15 == 47.7	10/21/25 11:45 == 47.8	10/21/25 16:15 == 47.6	10/21/25 20:45 == 47.8
10/21/25 7:20 == 47.9	10/21/25 11:50 == 48.2	10/21/25 16:20 == 48	10/21/25 20:50 == 47.9
10/21/25 7:25 == 48	10/21/25 11:55 == 47.8	10/21/25 16:25 == 48	10/21/25 20:55 == 47.7
10/21/25 7:30 == 48.1	10/21/25 12:00 == 47.6	10/21/25 16:30 == 48.1	10/21/25 21:00 == 47.6
10/21/25 7:35 == 47.9	10/21/25 12:05 == 47.8	10/21/25 16:35 == 48	10/21/25 21:05 == 48
10/21/25 7:40 == 47.3	10/21/25 12:10 == 48.1	10/21/25 16:40 == 48	10/21/25 21:10 == 47.9
10/21/25 7:45 == 47.4	10/21/25 12:15 == 48	10/21/25 16:45 == 47.3	10/21/25 21:15 == 47.8
10/21/25 7:50 == 48.1	10/21/25 12:20 == 48	10/21/25 16:50 == 47.9	10/21/25 21:20 == 47.8
10/21/25 7:55 == 48.1	10/21/25 12:25 == 48.1	10/21/25 16:55 == 48	10/21/25 21:25 == 47.7
10/21/25 8:00 == 47.9	10/21/25 12:30 == 48.2	10/21/25 17:00 == 47.8	10/21/25 21:30 == 47.3
10/21/25 8:05 == 47.9	10/21/25 12:35 == 48	10/21/25 17:05 == 47.6	10/21/25 21:35 == 47.9
10/21/25 8:10 == 47.9	10/21/25 12:40 == 48	10/21/25 17:10 == 48	10/21/25 21:40 == 47.9
10/21/25 8:15 == 48	10/21/25 12:45 == 48	10/21/25 17:15 == 47.9	10/21/25 21:45 == 48.2
10/21/25 8:20 == 48	10/21/25 12:50 == 48	10/21/25 17:20 == 48	10/21/25 21:50 == 48
10/21/25 8:25 == 47.8	10/21/25 12:55 == 48	10/21/25 17:25 == 47.7	10/21/25 21:55 == 48
10/21/25 8:30 == 48	10/21/25 13:00 == 48	10/21/25 17:30 == 47.9	10/21/25 22:00 == 48.1
10/21/25 8:35 == 48.1	10/21/25 13:05 == 48	10/21/25 17:35 == 47.9	10/21/25 22:05 == 48
10/21/25 8:40 == 47.9	10/21/25 13:10 == 47.9	10/21/25 17:40 == 47.9	10/21/25 22:10 == 48
10/21/25 8:45 == 47.6	10/21/25 13:15 == 48	10/21/25 17:45 == 47.9	10/21/25 22:15 == 48
10/21/25 8:50 == 47.9	10/21/25 13:20 == 48.1	10/21/25 17:50 == 48	10/21/25 22:20 == 47.9
10/21/25 8:55 == 47.8	10/21/25 13:25 == 48.1	10/21/25 17:55 == 47.9	10/21/25 22:25 == 48
10/21/25 9:00 == 47.9	10/21/25 13:30 == 48.1	10/21/25 18:00 == 47.9	10/21/25 22:30 == 48.1
10/21/25 9:05 == 47.9	10/21/25 13:35 == 48.1	10/21/25 18:05 == 47.9	10/21/25 22:35 == 48.1
10/21/25 9:10 == 48	10/21/25 13:40 == 47.9	10/21/25 18:10 == 47.9	10/21/25 22:40 == 48.1
10/21/25 9:15 == 48.1	10/21/25 13:45 == 48.1	10/21/25 18:15 == 47.8	10/21/25 22:45 == 48
10/21/25 9:20 == 48.1	10/21/25 13:50 == 47.9	10/21/25 18:20 == 47.8	10/21/25 22:50 == 48
10/21/25 9:25 == 48	10/21/25 13:55 == 48	10/21/25 18:25 == 47.9	10/21/25 22:55 == 48
10/21/25 9:30 == 48	10/21/25 14:00 == 48.1	10/21/25 18:30 == 48	10/21/25 23:00 == 47.8
10/21/25 9:35 == 47.9	10/21/25 14:05 == 48	10/21/25 18:35 == 47.9	10/21/25 23:05 == 47.9
10/21/25 9:40 == 48	10/21/25 14:10 == 47.9	10/21/25 18:40 == 47.9	10/21/25 23:10 == 47.8
10/21/25 9:45 == 48	10/21/25 14:15 == 48	10/21/25 18:45 == 48.1	10/21/25 23:15 == 47.7
10/21/25 9:50 == 47.9	10/21/25 14:20 == 48	10/21/25 18:50 == 48	10/21/25 23:20 == 48
10/21/25 9:55 == 48.1	10/21/25 14:25 == 47.3	10/21/25 18:55 == 47.3	10/21/25 23:25 == 48
10/21/25 10:00 == 48	10/21/25 14:30 == 47.6	10/21/25 19:00 == 48	10/21/25 23:30 == 47.9
10/21/25 10:05 == 47.9	10/21/25 14:35 == 47.7	10/21/25 19:05 == 48	10/21/25 23:35 == 48
10/21/25 10:10 == 47.5	10/21/25 14:40 == 48	10/21/25 19:10 == 48	10/21/25 23:40 == 47.8
10/21/25 10:15 == 47.7	10/21/25 14:45 == 47.9	10/21/25 19:15 == 48	10/21/25 23:45 == 47.9
10/21/25 10:20 == 48	10/21/25 14:50 == 47.8	10/21/25 19:20 == 47.9	10/21/25 23:50 == 48
10/21/25 10:25 == 47.8	10/21/25 14:55 == 47.8	10/21/25 19:25 == 47.8	10/21/25 23:55 == 47.9

Pumpback Station Discharge (0364)

10/22/25 0:00 == 48	10/22/25 4:30 == 48.1	10/22/25 9:00 == 48	10/22/25 13:30 == 47.3
10/22/25 0:05 == 48	10/22/25 4:35 == 48	10/22/25 9:05 == 48	10/22/25 13:35 == 47.9
10/22/25 0:10 == 48	10/22/25 4:40 == 48	10/22/25 9:10 == 48	10/22/25 13:40 == 48.1
10/22/25 0:15 == 47.9	10/22/25 4:45 == 48	10/22/25 9:15 == 48	10/22/25 13:45 == 48
10/22/25 0:20 == 47.9	10/22/25 4:50 == 48.1	10/22/25 9:20 == 48.1	10/22/25 13:50 == 48.1
10/22/25 0:25 == 48.2	10/22/25 4:55 == 48.1	10/22/25 9:25 == 48	10/22/25 13:55 == 48
10/22/25 0:30 == 47.8	10/22/25 5:00 == 48	10/22/25 9:30 == 47.9	10/22/25 14:00 == 48.1
10/22/25 0:35 == 48.1	10/22/25 5:05 == 48	10/22/25 9:35 == 48	10/22/25 14:05 == 48
10/22/25 0:40 == 48	10/22/25 5:10 == 48.1	10/22/25 9:40 == 47.9	10/22/25 14:10 == 48
10/22/25 0:45 == 48	10/22/25 5:15 == 48	10/22/25 9:45 == 47.9	10/22/25 14:15 == 47.5
10/22/25 0:50 == 48.1	10/22/25 5:20 == 48.1	10/22/25 9:50 == 48.1	10/22/25 14:20 == 47.7
10/22/25 0:55 == 47.9	10/22/25 5:25 == 47.9	10/22/25 9:55 == 47.8	10/22/25 14:25 == 48
10/22/25 1:00 == 47.9	10/22/25 5:30 == 47.9	10/22/25 10:00 == 47.5	10/22/25 14:30 == 47.9
10/22/25 1:05 == 48	10/22/25 5:35 == 48	10/22/25 10:05 == 47.5	10/22/25 14:35 == 47.7
10/22/25 1:10 == 47.9	10/22/25 5:40 == 48	10/22/25 10:10 == 48.1	10/22/25 14:40 == 47.7
10/22/25 1:15 == 47.8	10/22/25 5:45 == 48	10/22/25 10:15 == 48	10/22/25 14:45 == 47.7
10/22/25 1:20 == 47.9	10/22/25 5:50 == 48	10/22/25 10:20 == 47.7	10/22/25 14:50 == 47.7
10/22/25 1:25 == 48	10/22/25 5:55 == 47.2	10/22/25 10:25 == 47.5	10/22/25 14:55 == 47.7
10/22/25 1:30 == 48	10/22/25 6:00 == 47.6	10/22/25 10:30 == 47.9	10/22/25 15:00 == 47.8
10/22/25 1:35 == 47.9	10/22/25 6:05 == 47.9	10/22/25 10:35 == 47.9	10/22/25 15:05 == 47.9
10/22/25 1:40 == 48	10/22/25 6:10 == 47.9	10/22/25 10:40 == 47.9	10/22/25 15:10 == 47.9
10/22/25 1:45 == 48.1	10/22/25 6:15 == 48	10/22/25 10:45 == 47.7	10/22/25 15:15 == 48
10/22/25 1:50 == 48.1	10/22/25 6:20 == 48.1	10/22/25 10:50 == 47.9	10/22/25 15:20 == 48
10/22/25 1:55 == 47.9	10/22/25 6:25 == 48	10/22/25 10:55 == 48.1	10/22/25 15:25 == 48.1
10/22/25 2:00 == 47.8	10/22/25 6:30 == 48	10/22/25 11:00 == 47.9	10/22/25 15:30 == 48.1
10/22/25 2:05 == 47.8	10/22/25 6:35 == 48.1	10/22/25 11:05 == 48.1	10/22/25 15:35 == 47.8
10/22/25 2:10 == 47.6	10/22/25 6:40 == 48.1	10/22/25 11:10 == 47.8	10/22/25 15:40 == 47.8
10/22/25 2:15 == 47.9	10/22/25 6:45 == 48.1	10/22/25 11:15 == 47.7	10/22/25 15:45 == 47.2
10/22/25 2:20 == 48	10/22/25 6:50 == 48.1	10/22/25 11:20 == 48.1	10/22/25 15:50 == 47.9
10/22/25 2:25 == 48	10/22/25 6:55 == 48	10/22/25 11:25 == 47.6	10/22/25 15:55 == 47.5
10/22/25 2:30 == 47.9	10/22/25 7:00 == 47.8	10/22/25 11:30 == 47.9	10/22/25 16:00 == 48
10/22/25 2:35 == 47.9	10/22/25 7:05 == 47.7	10/22/25 11:35 == 48.1	10/22/25 16:05 == 48
10/22/25 2:40 == 48	10/22/25 7:10 == 47.6	10/22/25 11:40 == 48	10/22/25 16:10 == 48
10/22/25 2:45 == 48	10/22/25 7:15 == 47.6	10/22/25 11:45 == 48	10/22/25 16:15 == 48
10/22/25 2:50 == 47.8	10/22/25 7:20 == 47.8	10/22/25 11:50 == 48	10/22/25 16:20 == 47.8
10/22/25 2:55 == 47.9	10/22/25 7:25 == 47.9	10/22/25 11:55 == 47.8	10/22/25 16:25 == 48
10/22/25 3:00 == 47.8	10/22/25 7:30 == 47.8	10/22/25 12:00 == 47.7	10/22/25 16:30 == 47.9
10/22/25 3:05 == 48	10/22/25 7:35 == 47.8	10/22/25 12:05 == 47.9	10/22/25 16:35 == 47.6
10/22/25 3:10 == 47.9	10/22/25 7:40 == 47.5	10/22/25 12:10 == 48	10/22/25 16:40 == 47.3
10/22/25 3:15 == 47.9	10/22/25 7:45 == 48	10/22/25 12:15 == 48	10/22/25 16:45 == 47.7
10/22/25 3:20 == 47.9	10/22/25 7:50 == 48	10/22/25 12:20 == 47.9	10/22/25 16:50 == 48
10/22/25 3:25 == 47.9	10/22/25 7:55 == 48.1	10/22/25 12:25 == 48	10/22/25 16:55 == 47.9
10/22/25 3:30 == 48	10/22/25 8:00 == 48	10/22/25 12:30 == 47.9	10/22/25 17:00 == 47.9
10/22/25 3:35 == 48.1	10/22/25 8:05 == 47.8	10/22/25 12:35 == 47.8	10/22/25 17:05 == 48
10/22/25 3:40 == 47.9	10/22/25 8:10 == 48	10/22/25 12:40 == 47.9	10/22/25 17:10 == 47.9
10/22/25 3:45 == 48	10/22/25 8:15 == 48	10/22/25 12:45 == 48	10/22/25 17:15 == 47.9
10/22/25 3:50 == 48.1	10/22/25 8:20 == 47.8	10/22/25 12:50 == 48.1	10/22/25 17:20 == 47.9
10/22/25 3:55 == 47.4	10/22/25 8:25 == 47.9	10/22/25 12:55 == 48.1	10/22/25 17:25 == 47.7
10/22/25 4:00 == 47.7	10/22/25 8:30 == 48	10/22/25 13:00 == 48.1	10/22/25 17:30 == 47.7
10/22/25 4:05 == 48.2	10/22/25 8:35 == 47.9	10/22/25 13:05 == 48	10/22/25 17:35 == 48
10/22/25 4:10 == 48	10/22/25 8:40 == 47.8	10/22/25 13:10 == 48.1	10/22/25 17:40 == 48.1
10/22/25 4:15 == 47.5	10/22/25 8:45 == 47.9	10/22/25 13:15 == 47.9	10/22/25 17:45 == 48
10/22/25 4:20 == 47.6	10/22/25 8:50 == 48	10/22/25 13:20 == 47.9	10/22/25 17:50 == 47.9
10/22/25 4:25 == 48	10/22/25 8:55 == 48	10/22/25 13:25 == 47.9	10/22/25 17:55 == 47.4

Pumpback Station Discharge (0364)

10/22/25 18:00 == 47.9	10/22/25 22:30 == 48	10/23/25 3:00 == 47.9	10/23/25 7:30 == 47.9
10/22/25 18:05 == 48	10/22/25 22:35 == 48	10/23/25 3:05 == 48	10/23/25 7:35 == 48
10/22/25 18:10 == 48	10/22/25 22:40 == 48	10/23/25 3:10 == 48	10/23/25 7:40 == 47.4
10/22/25 18:15 == 48	10/22/25 22:45 == 48	10/23/25 3:15 == 48	10/23/25 7:45 == 47.9
10/22/25 18:20 == 48.1	10/22/25 22:50 == 48	10/23/25 3:20 == 47.9	10/23/25 7:50 == 48
10/22/25 18:25 == 47.8	10/22/25 22:55 == 48	10/23/25 3:25 == 47.9	10/23/25 7:55 == 47.8
10/22/25 18:30 == 48	10/22/25 23:00 == 47.9	10/23/25 3:30 == 48	10/23/25 8:00 == 48
10/22/25 18:35 == 48.1	10/22/25 23:05 == 47.9	10/23/25 3:35 == 48	10/23/25 8:05 == 48
10/22/25 18:40 == 48	10/22/25 23:10 == 47.5	10/23/25 3:40 == 48	10/23/25 8:10 == 48.1
10/22/25 18:45 == 48	10/22/25 23:15 == 47.6	10/23/25 3:45 == 47.9	10/23/25 8:15 == 48
10/22/25 18:50 == 48	10/22/25 23:20 == 47.7	10/23/25 3:50 == 47.8	10/23/25 8:20 == 48
10/22/25 18:55 == 47.5	10/22/25 23:25 == 48	10/23/25 3:55 == 47.6	10/23/25 8:25 == 48
10/22/25 19:00 == 47.9	10/22/25 23:30 == 47.8	10/23/25 4:00 == 47.9	10/23/25 8:30 == 47.9
10/22/25 19:05 == 47.9	10/22/25 23:35 == 48.1	10/23/25 4:05 == 48	10/23/25 8:35 == 47.9
10/22/25 19:10 == 48	10/22/25 23:40 == 47.8	10/23/25 4:10 == 48	10/23/25 8:40 == 48
10/22/25 19:15 == 48.1	10/22/25 23:45 == 48	10/23/25 4:15 == 47.9	10/23/25 8:45 == 48
10/22/25 19:20 == 48	10/22/25 23:50 == 47.9	10/23/25 4:20 == 47.9	10/23/25 8:50 == 48
10/22/25 19:25 == 48	10/22/25 23:55 == 47.8	10/23/25 4:25 == 48	10/23/25 8:55 == 47.8
10/22/25 19:30 == 48	10/23/25 0:00 == 48.1	10/23/25 4:30 == 48.1	10/23/25 9:00 == 47.8
10/22/25 19:35 == 48	10/23/25 0:05 == 48	10/23/25 4:35 == 48	10/23/25 9:05 == 47.9
10/22/25 19:40 == 47.9	10/23/25 0:10 == 47.9	10/23/25 4:40 == 47.9	10/23/25 9:10 == 47.9
10/22/25 19:45 == 47.9	10/23/25 0:15 == 48	10/23/25 4:45 == 48	10/23/25 9:15 == 47.9
10/22/25 19:50 == 48	10/23/25 0:20 == 48.1	10/23/25 4:50 == 48.1	10/23/25 9:20 == 47.9
10/22/25 19:55 == 48	10/23/25 0:25 == 48	10/23/25 4:55 == 47.9	10/23/25 9:25 == 48
10/22/25 20:00 == 47.9	10/23/25 0:30 == 48	10/23/25 5:00 == 47.8	10/23/25 9:30 == 47.9
10/22/25 20:05 == 47.9	10/23/25 0:35 == 47.9	10/23/25 5:05 == 47.9	10/23/25 9:35 == 48
10/22/25 20:10 == 48	10/23/25 0:40 == 47.9	10/23/25 5:10 == 48	10/23/25 9:40 == 47.9
10/22/25 20:15 == 48.1	10/23/25 0:45 == 48	10/23/25 5:15 == 48.1	10/23/25 9:45 == 47.9
10/22/25 20:20 == 48	10/23/25 0:50 == 47.8	10/23/25 5:20 == 48.1	10/23/25 9:50 == 47.9
10/22/25 20:25 == 47.4	10/23/25 0:55 == 47.6	10/23/25 5:25 == 47.6	10/23/25 9:55 == 47.9
10/22/25 20:30 == 47.9	10/23/25 1:00 == 47.8	10/23/25 5:30 == 47.8	10/23/25 10:00 == 47.9
10/22/25 20:35 == 47.9	10/23/25 1:05 == 48	10/23/25 5:35 == 47.9	10/23/25 10:05 == 47.8
10/22/25 20:40 == 47.4	10/23/25 1:10 == 48	10/23/25 5:40 == 48.1	10/23/25 10:10 == 47.9
10/22/25 20:45 == 47.8	10/23/25 1:15 == 47.9	10/23/25 5:45 == 48.1	10/23/25 10:15 == 47.8
10/22/25 20:50 == 48	10/23/25 1:20 == 48	10/23/25 5:50 == 48	10/23/25 10:20 == 47.9
10/22/25 20:55 == 47.5	10/23/25 1:25 == 48	10/23/25 5:55 == 47.9	10/23/25 10:25 == 48
10/22/25 21:00 == 47.6	10/23/25 1:30 == 47.9	10/23/25 6:00 == 47.9	10/23/25 10:30 == 47.9
10/22/25 21:05 == 48.1	10/23/25 1:35 == 47.9	10/23/25 6:05 == 48	10/23/25 10:35 == 47.9
10/22/25 21:10 == 47.7	10/23/25 1:40 == 48	10/23/25 6:10 == 48	10/23/25 10:40 == 47.8
10/22/25 21:15 == 47.8	10/23/25 1:45 == 47.9	10/23/25 6:15 == 48	10/23/25 10:45 == 47.6
10/22/25 21:20 == 48	10/23/25 1:50 == 48	10/23/25 6:20 == 48	10/23/25 10:50 == 47.9
10/22/25 21:25 == 47.9	10/23/25 1:55 == 47.7	10/23/25 6:25 == 48	10/23/25 10:55 == 48
10/22/25 21:30 == 47.9	10/23/25 2:00 == 48	10/23/25 6:30 == 47.9	10/23/25 11:00 == 47.8
10/22/25 21:35 == 48	10/23/25 2:05 == 48.1	10/23/25 6:35 == 47.7	10/23/25 11:05 == 48
10/22/25 21:40 == 47.9	10/23/25 2:10 == 48	10/23/25 6:40 == 47.4	10/23/25 11:10 == 47.5
10/22/25 21:45 == 48	10/23/25 2:15 == 48.1	10/23/25 6:45 == 47.7	10/23/25 11:15 == 47.4
10/22/25 21:50 == 47.9	10/23/25 2:20 == 48	10/23/25 6:50 == 48.1	10/23/25 11:20 == 47.8
10/22/25 21:55 == 47.9	10/23/25 2:25 == 47.5	10/23/25 6:55 == 48	10/23/25 11:25 == 47.6
10/22/25 22:00 == 48	10/23/25 2:30 == 47.9	10/23/25 7:00 == 47.9	10/23/25 11:30 == 47.8
10/22/25 22:05 == 48.1	10/23/25 2:35 == 47.9	10/23/25 7:05 == 47.7	10/23/25 11:35 == 48
10/22/25 22:10 == 47.9	10/23/25 2:40 == 47.9	10/23/25 7:10 == 47.5	10/23/25 11:40 == 48
10/22/25 22:15 == 48	10/23/25 2:45 == 47.9	10/23/25 7:15 == 47.9	10/23/25 11:45 == 48
10/22/25 22:20 == 48.1	10/23/25 2:50 == 48	10/23/25 7:20 == 48	10/23/25 11:50 == 47.9
10/22/25 22:25 == 48	10/23/25 2:55 == 47.7	10/23/25 7:25 == 48	10/23/25 11:55 == 47.6

Pumpback Station Discharge (0364)

10/23/25 12:00 == 48.1	10/23/25 16:30 == 47.9	10/23/25 21:00 == 47.8	10/24/25 1:30 == 47.9
10/23/25 12:05 == 48	10/23/25 16:35 == 48	10/23/25 21:05 == 47.9	10/24/25 1:35 == 47.9
10/23/25 12:10 == 47.8	10/23/25 16:40 == 47.7	10/23/25 21:10 == 48	10/24/25 1:40 == 47.9
10/23/25 12:15 == 47.9	10/23/25 16:45 == 47.5	10/23/25 21:15 == 48	10/24/25 1:45 == 48.1
10/23/25 12:20 == 48.1	10/23/25 16:50 == 47.8	10/23/25 21:20 == 48.1	10/24/25 1:50 == 47.9
10/23/25 12:25 == 47.5	10/23/25 16:55 == 47.9	10/23/25 21:25 == 48	10/24/25 1:55 == 47.5
10/23/25 12:30 == 47.8	10/23/25 17:00 == 48	10/23/25 21:30 == 47.8	10/24/25 2:00 == 48
10/23/25 12:35 == 48	10/23/25 17:05 == 47.9	10/23/25 21:35 == 47.9	10/24/25 2:05 == 47.6
10/23/25 12:40 == 47.8	10/23/25 17:10 == 48	10/23/25 21:40 == 48	10/24/25 2:10 == 47.7
10/23/25 12:45 == 48	10/23/25 17:15 == 47.9	10/23/25 21:45 == 48.1	10/24/25 2:15 == 48
10/23/25 12:50 == 47.9	10/23/25 17:20 == 48.1	10/23/25 21:50 == 48.1	10/24/25 2:20 == 48
10/23/25 12:55 == 48.1	10/23/25 17:25 == 48	10/23/25 21:55 == 48.1	10/24/25 2:25 == 47.5
10/23/25 13:00 == 48	10/23/25 17:30 == 47.4	10/23/25 22:00 == 48.1	10/24/25 2:30 == 47.6
10/23/25 13:05 == 48	10/23/25 17:35 == 48	10/23/25 22:05 == 47.9	10/24/25 2:35 == 48
10/23/25 13:10 == 48	10/23/25 17:40 == 47.9	10/23/25 22:10 == 47.9	10/24/25 2:40 == 48
10/23/25 13:15 == 48.1	10/23/25 17:45 == 48	10/23/25 22:15 == 48.1	10/24/25 2:45 == 48
10/23/25 13:20 == 48	10/23/25 17:50 == 47.9	10/23/25 22:20 == 47.9	10/24/25 2:50 == 47.7
10/23/25 13:25 == 47.9	10/23/25 17:55 == 47.3	10/23/25 22:25 == 48	10/24/25 2:55 == 47.4
10/23/25 13:30 == 47.9	10/23/25 18:00 == 47.8	10/23/25 22:30 == 48	10/24/25 3:00 == 47.5
10/23/25 13:35 == 47.9	10/23/25 18:05 == 48	10/23/25 22:35 == 48.1	10/24/25 3:05 == 47.9
10/23/25 13:40 == 47.9	10/23/25 18:10 == 48	10/23/25 22:40 == 47.8	10/24/25 3:10 == 48
10/23/25 13:45 == 47.9	10/23/25 18:15 == 47.9	10/23/25 22:45 == 47.9	10/24/25 3:15 == 48.1
10/23/25 13:50 == 48	10/23/25 18:20 == 48	10/23/25 22:50 == 48	10/24/25 3:20 == 48.1
10/23/25 13:55 == 48	10/23/25 18:25 == 47.8	10/23/25 22:55 == 48	10/24/25 3:25 == 48
10/23/25 14:00 == 48	10/23/25 18:30 == 47.9	10/23/25 23:00 == 47.9	10/24/25 3:30 == 47.9
10/23/25 14:05 == 48	10/23/25 18:35 == 48	10/23/25 23:05 == 48	10/24/25 3:35 == 47.9
10/23/25 14:10 == 47.9	10/23/25 18:40 == 48	10/23/25 23:10 == 47.7	10/24/25 3:40 == 48
10/23/25 14:15 == 48	10/23/25 18:45 == 48.1	10/23/25 23:15 == 47.8	10/24/25 3:45 == 47.9
10/23/25 14:20 == 48	10/23/25 18:50 == 48.1	10/23/25 23:20 == 48	10/24/25 3:50 == 47.9
10/23/25 14:25 == 48	10/23/25 18:55 == 47.9	10/23/25 23:25 == 47.9	10/24/25 3:55 == 47.3
10/23/25 14:30 == 48	10/23/25 19:00 == 47.7	10/23/25 23:30 == 47.9	10/24/25 4:00 == 47.8
10/23/25 14:35 == 48	10/23/25 19:05 == 47.9	10/23/25 23:35 == 47.9	10/24/25 4:05 == 48
10/23/25 14:40 == 48	10/23/25 19:10 == 48	10/23/25 23:40 == 47.6	10/24/25 4:10 == 48.1
10/23/25 14:45 == 48	10/23/25 19:15 == 47.9	10/23/25 23:45 == 47.7	10/24/25 4:15 == 47.9
10/23/25 14:50 == 48.1	10/23/25 19:20 == 48	10/23/25 23:50 == 47.6	10/24/25 4:20 == 48
10/23/25 14:55 == 48.1	10/23/25 19:25 == 48	10/23/25 23:55 == 47.7	10/24/25 4:25 == 47.9
10/23/25 15:00 == 47.9	10/23/25 19:30 == 47.9	10/24/25 0:00 == 48	10/24/25 4:30 == 47.9
10/23/25 15:05 == 47.9	10/23/25 19:35 == 48	10/24/25 0:05 == 48.2	10/24/25 4:35 == 47.9
10/23/25 15:10 == 47.3	10/23/25 19:40 == 48	10/24/25 0:10 == 48.1	10/24/25 4:40 == 47.9
10/23/25 15:15 == 47.8	10/23/25 19:45 == 47.9	10/24/25 0:15 == 48	10/24/25 4:45 == 47.9
10/23/25 15:20 == 47.9	10/23/25 19:50 == 47.7	10/24/25 0:20 == 48.1	10/24/25 4:50 == 48
10/23/25 15:25 == 48.1	10/23/25 19:55 == 48	10/24/25 0:25 == 48	10/24/25 4:55 == 48
10/23/25 15:30 == 48	10/23/25 20:00 == 47.9	10/24/25 0:30 == 47.8	10/24/25 5:00 == 48
10/23/25 15:35 == 47.9	10/23/25 20:05 == 48	10/24/25 0:35 == 47.9	10/24/25 5:05 == 48
10/23/25 15:40 == 47.3	10/23/25 20:10 == 48	10/24/25 0:40 == 48	10/24/25 5:10 == 48
10/23/25 15:45 == 47.7	10/23/25 20:15 == 47.9	10/24/25 0:45 == 48	10/24/25 5:15 == 48
10/23/25 15:50 == 48.1	10/23/25 20:20 == 48.1	10/24/25 0:50 == 47.9	10/24/25 5:20 == 47.9
10/23/25 15:55 == 47.7	10/23/25 20:25 == 47.4	10/24/25 0:55 == 47.8	10/24/25 5:25 == 48
10/23/25 16:00 == 47.7	10/23/25 20:30 == 47.9	10/24/25 1:00 == 48.1	10/24/25 5:30 == 48.1
10/23/25 16:05 == 47.9	10/23/25 20:35 == 48	10/24/25 1:05 == 48.1	10/24/25 5:35 == 48
10/23/25 16:10 == 47.9	10/23/25 20:40 == 47.4	10/24/25 1:10 == 47.8	10/24/25 5:40 == 48
10/23/25 16:15 == 48	10/23/25 20:45 == 47.7	10/24/25 1:15 == 47.9	10/24/25 5:45 == 48
10/23/25 16:20 == 48.1	10/23/25 20:50 == 47.8	10/24/25 1:20 == 48	10/24/25 5:50 == 48
10/23/25 16:25 == 48	10/23/25 20:55 == 47.4	10/24/25 1:25 == 47.4	10/24/25 5:55 == 47.8

Pumpback Station Discharge (0364)

10/24/25 6:00 == 48	10/24/25 10:30 == 48	10/24/25 15:00 == 47.9	10/24/25 19:30 == 48
10/24/25 6:05 == 48	10/24/25 10:35 == 47.8	10/24/25 15:05 == 47.9	10/24/25 19:35 == 48
10/24/25 6:10 == 48.1	10/24/25 10:40 == 47.8	10/24/25 15:10 == 47.5	10/24/25 19:40 == 47.9
10/24/25 6:15 == 48.1	10/24/25 10:45 == 47.7	10/24/25 15:15 == 47.7	10/24/25 19:45 == 48
10/24/25 6:20 == 48.1	10/24/25 10:50 == 47.4	10/24/25 15:20 == 48	10/24/25 19:50 == 47.9
10/24/25 6:25 == 48	10/24/25 10:55 == 47.8	10/24/25 15:25 == 48	10/24/25 19:55 == 47.8
10/24/25 6:30 == 48	10/24/25 11:00 == 48	10/24/25 15:30 == 47.9	10/24/25 20:00 == 47.9
10/24/25 6:35 == 47.9	10/24/25 11:05 == 47.9	10/24/25 15:35 == 47.7	10/24/25 20:05 == 48
10/24/25 6:40 == 47.5	10/24/25 11:10 == 47.2	10/24/25 15:40 == 47.6	10/24/25 20:10 == 47.8
10/24/25 6:45 == 47.9	10/24/25 11:15 == 47.9	10/24/25 15:45 == 47.9	10/24/25 20:15 == 47.9
10/24/25 6:50 == 48.1	10/24/25 11:20 == 48	10/24/25 15:50 == 47.8	10/24/25 20:20 == 48
10/24/25 6:55 == 48.1	10/24/25 11:25 == 47.4	10/24/25 15:55 == 47.6	10/24/25 20:25 == 47.7
10/24/25 7:00 == 47.9	10/24/25 11:30 == 47.9	10/24/25 16:00 == 48.1	10/24/25 20:30 == 47.6
10/24/25 7:05 == 48	10/24/25 11:35 == 47.9	10/24/25 16:05 == 47.9	10/24/25 20:35 == 47.7
10/24/25 7:10 == 47.4	10/24/25 11:40 == 48	10/24/25 16:10 == 47.8	10/24/25 20:40 == 47.6
10/24/25 7:15 == 47.6	10/24/25 11:45 == 48	10/24/25 16:15 == 47.9	10/24/25 20:45 == 47.7
10/24/25 7:20 == 47.4	10/24/25 11:50 == 48	10/24/25 16:20 == 47.9	10/24/25 20:50 == 47.8
10/24/25 7:25 == 47.6	10/24/25 11:55 == 47.5	10/24/25 16:25 == 47.9	10/24/25 20:55 == 47.6
10/24/25 7:30 == 47.9	10/24/25 12:00 == 47.6	10/24/25 16:30 == 48.1	10/24/25 21:00 == 47.6
10/24/25 7:35 == 47.8	10/24/25 12:05 == 48	10/24/25 16:35 == 48.1	10/24/25 21:05 == 47.9
10/24/25 7:40 == 47.6	10/24/25 12:10 == 47.9	10/24/25 16:40 == 47.9	10/24/25 21:10 == 47.8
10/24/25 7:45 == 47.7	10/24/25 12:15 == 48	10/24/25 16:45 == 47.5	10/24/25 21:15 == 47.5
10/24/25 7:50 == 47.9	10/24/25 12:20 == 47.7	10/24/25 16:50 == 47.9	10/24/25 21:20 == 47.7
10/24/25 7:55 == 48	10/24/25 12:25 == 47.8	10/24/25 16:55 == 48	10/24/25 21:25 == 47.9
10/24/25 8:00 == 48	10/24/25 12:30 == 48.1	10/24/25 17:00 == 48	10/24/25 21:30 == 48
10/24/25 8:05 == 48	10/24/25 12:35 == 48	10/24/25 17:05 == 47.9	10/24/25 21:35 == 47.9
10/24/25 8:10 == 48	10/24/25 12:40 == 48	10/24/25 17:10 == 47.9	10/24/25 21:40 == 47.9
10/24/25 8:15 == 48	10/24/25 12:45 == 48.1	10/24/25 17:15 == 48	10/24/25 21:45 == 48.1
10/24/25 8:20 == 48.1	10/24/25 12:50 == 48	10/24/25 17:20 == 48	10/24/25 21:50 == 47.9
10/24/25 8:25 == 47.9	10/24/25 12:55 == 47.9	10/24/25 17:25 == 48	10/24/25 21:55 == 48
10/24/25 8:30 == 48.1	10/24/25 13:00 == 47.9	10/24/25 17:30 == 48	10/24/25 22:00 == 48.1
10/24/25 8:35 == 48.1	10/24/25 13:05 == 47.9	10/24/25 17:35 == 47.9	10/24/25 22:05 == 47.8
10/24/25 8:40 == 48	10/24/25 13:10 == 47.9	10/24/25 17:40 == 47.9	10/24/25 22:10 == 48.1
10/24/25 8:45 == 48	10/24/25 13:15 == 47.9	10/24/25 17:45 == 47.9	10/24/25 22:15 == 47.9
10/24/25 8:50 == 47.8	10/24/25 13:20 == 48	10/24/25 17:50 == 48.1	10/24/25 22:20 == 48.1
10/24/25 8:55 == 48	10/24/25 13:25 == 47.9	10/24/25 17:55 == 47.4	10/24/25 22:25 == 48.1
10/24/25 9:00 == 47.9	10/24/25 13:30 == 48	10/24/25 18:00 == 47.4	10/24/25 22:30 == 48
10/24/25 9:05 == 48.2	10/24/25 13:35 == 48.1	10/24/25 18:05 == 48.1	10/24/25 22:35 == 48
10/24/25 9:10 == 48.1	10/24/25 13:40 == 48	10/24/25 18:10 == 48.1	10/24/25 22:40 == 48
10/24/25 9:15 == 48	10/24/25 13:45 == 48	10/24/25 18:15 == 48.2	10/24/25 22:45 == 47.9
10/24/25 9:20 == 47.9	10/24/25 13:50 == 48	10/24/25 18:20 == 48	10/24/25 22:50 == 47.9
10/24/25 9:25 == 47.8	10/24/25 13:55 == 47.9	10/24/25 18:25 == 47.7	10/24/25 22:55 == 48
10/24/25 9:30 == 48	10/24/25 14:00 == 48.1	10/24/25 18:30 == 47.9	10/24/25 23:00 == 47.9
10/24/25 9:35 == 48.1	10/24/25 14:05 == 47.9	10/24/25 18:35 == 48	10/24/25 23:05 == 47.9
10/24/25 9:40 == 47.9	10/24/25 14:10 == 48	10/24/25 18:40 == 48	10/24/25 23:10 == 47.7
10/24/25 9:45 == 47.6	10/24/25 14:15 == 48.1	10/24/25 18:45 == 48	10/24/25 23:15 == 47.8
10/24/25 9:50 == 47.9	10/24/25 14:20 == 48	10/24/25 18:50 == 47.8	10/24/25 23:20 == 48
10/24/25 9:55 == 48	10/24/25 14:25 == 47.9	10/24/25 18:55 == 47.8	10/24/25 23:25 == 47.9
10/24/25 10:00 == 48	10/24/25 14:30 == 48	10/24/25 19:00 == 47.7	10/24/25 23:30 == 47.9
10/24/25 10:05 == 48.1	10/24/25 14:35 == 48	10/24/25 19:05 == 48	10/24/25 23:35 == 48
10/24/25 10:10 == 47.8	10/24/25 14:40 == 48.1	10/24/25 19:10 == 48	10/24/25 23:40 == 48.1
10/24/25 10:15 == 47.7	10/24/25 14:45 == 47.5	10/24/25 19:15 == 47.7	10/24/25 23:45 == 47.9
10/24/25 10:20 == 48	10/24/25 14:50 == 47.5	10/24/25 19:20 == 47.9	10/24/25 23:50 == 48
10/24/25 10:25 == 48.1	10/24/25 14:55 == 47.7	10/24/25 19:25 == 47.9	10/24/25 23:55 == 48

Pumpback Station Discharge (0364)

10/25/25 0:00 == 48	10/25/25 4:30 == 48	10/25/25 9:00 == 48.1	10/25/25 13:30 == 47.9
10/25/25 0:05 == 47.8	10/25/25 4:35 == 48.1	10/25/25 9:05 == 48	10/25/25 13:35 == 47.7
10/25/25 0:10 == 48.1	10/25/25 4:40 == 48.2	10/25/25 9:10 == 48	10/25/25 13:40 == 47.9
10/25/25 0:15 == 47.9	10/25/25 4:45 == 48	10/25/25 9:15 == 47.9	10/25/25 13:45 == 48
10/25/25 0:20 == 48	10/25/25 4:50 == 47.9	10/25/25 9:20 == 48	10/25/25 13:50 == 47.9
10/25/25 0:25 == 48	10/25/25 4:55 == 47.6	10/25/25 9:25 == 48	10/25/25 13:55 == 47.9
10/25/25 0:30 == 48.1	10/25/25 5:00 == 47.9	10/25/25 9:30 == 47.8	10/25/25 14:00 == 47.9
10/25/25 0:35 == 48.1	10/25/25 5:05 == 48	10/25/25 9:35 == 48	10/25/25 14:05 == 47.9
10/25/25 0:40 == 48	10/25/25 5:10 == 47.9	10/25/25 9:40 == 47.8	10/25/25 14:10 == 47.9
10/25/25 0:45 == 48	10/25/25 5:15 == 47.8	10/25/25 9:45 == 47.5	10/25/25 14:15 == 47.9
10/25/25 0:50 == 48.1	10/25/25 5:20 == 47.8	10/25/25 9:50 == 47.9	10/25/25 14:20 == 47.8
10/25/25 0:55 == 48.1	10/25/25 5:25 == 47.3	10/25/25 9:55 == 47.8	10/25/25 14:25 == 47.9
10/25/25 1:00 == 48	10/25/25 5:30 == 47.9	10/25/25 10:00 == 47.9	10/25/25 14:30 == 47.8
10/25/25 1:05 == 48	10/25/25 5:35 == 48.1	10/25/25 10:05 == 48	10/25/25 14:35 == 47.8
10/25/25 1:10 == 47.9	10/25/25 5:40 == 47.9	10/25/25 10:10 == 47.8	10/25/25 14:40 == 48
10/25/25 1:15 == 48	10/25/25 5:45 == 48.1	10/25/25 10:15 == 48	10/25/25 14:45 == 47.9
10/25/25 1:20 == 48	10/25/25 5:50 == 47.9	10/25/25 10:20 == 47.8	10/25/25 14:50 == 47.9
10/25/25 1:25 == 47.9	10/25/25 5:55 == 47.7	10/25/25 10:25 == 47.9	10/25/25 14:55 == 47.8
10/25/25 1:30 == 47.8	10/25/25 6:00 == 47.9	10/25/25 10:30 == 47.8	10/25/25 15:00 == 47.8
10/25/25 1:35 == 47.8	10/25/25 6:05 == 48	10/25/25 10:35 == 47.8	10/25/25 15:05 == 48
10/25/25 1:40 == 47.9	10/25/25 6:10 == 47.8	10/25/25 10:40 == 47.9	10/25/25 15:10 == 47.9
10/25/25 1:45 == 48	10/25/25 6:15 == 47.9	10/25/25 10:45 == 47.7	10/25/25 15:15 == 48
10/25/25 1:50 == 48.1	10/25/25 6:20 == 47.9	10/25/25 10:50 == 48.2	10/25/25 15:20 == 48.2
10/25/25 1:55 == 47.9	10/25/25 6:25 == 47.9	10/25/25 10:55 == 47.9	10/25/25 15:25 == 47.9
10/25/25 2:00 == 47.9	10/25/25 6:30 == 47.9	10/25/25 11:00 == 48	10/25/25 15:30 == 47.9
10/25/25 2:05 == 48	10/25/25 6:35 == 48	10/25/25 11:05 == 48.2	10/25/25 15:35 == 48
10/25/25 2:10 == 47.9	10/25/25 6:40 == 47.7	10/25/25 11:10 == 47.3	10/25/25 15:40 == 47.6
10/25/25 2:15 == 48	10/25/25 6:45 == 47.8	10/25/25 11:15 == 47.9	10/25/25 15:45 == 47.6
10/25/25 2:20 == 47.8	10/25/25 6:50 == 48	10/25/25 11:20 == 48	10/25/25 15:50 == 47.9
10/25/25 2:25 == 47.4	10/25/25 6:55 == 47.9	10/25/25 11:25 == 47.2	10/25/25 15:55 == 47.2
10/25/25 2:30 == 47.9	10/25/25 7:00 == 48	10/25/25 11:30 == 47.7	10/25/25 16:00 == 47.9
10/25/25 2:35 == 47.9	10/25/25 7:05 == 47.8	10/25/25 11:35 == 48.1	10/25/25 16:05 == 47.9
10/25/25 2:40 == 48	10/25/25 7:10 == 47.4	10/25/25 11:40 == 48	10/25/25 16:10 == 47.9
10/25/25 2:45 == 47.9	10/25/25 7:15 == 47.6	10/25/25 11:45 == 48	10/25/25 16:15 == 47.9
10/25/25 2:50 == 48.1	10/25/25 7:20 == 48	10/25/25 11:50 == 47.8	10/25/25 16:20 == 47.8
10/25/25 2:55 == 47.5	10/25/25 7:25 == 47.8	10/25/25 11:55 == 47.5	10/25/25 16:25 == 47.9
10/25/25 3:00 == 47.6	10/25/25 7:30 == 48	10/25/25 12:00 == 47.7	10/25/25 16:30 == 47.9
10/25/25 3:05 == 47.8	10/25/25 7:35 == 47.8	10/25/25 12:05 == 47.8	10/25/25 16:35 == 47.9
10/25/25 3:10 == 48	10/25/25 7:40 == 47.5	10/25/25 12:10 == 47.8	10/25/25 16:40 == 47.8
10/25/25 3:15 == 47.9	10/25/25 7:45 == 47.5	10/25/25 12:15 == 47.9	10/25/25 16:45 == 47.7
10/25/25 3:20 == 47.8	10/25/25 7:50 == 47.9	10/25/25 12:20 == 47.9	10/25/25 16:50 == 47.8
10/25/25 3:25 == 47.8	10/25/25 7:55 == 47.8	10/25/25 12:25 == 47.9	10/25/25 16:55 == 47.7
10/25/25 3:30 == 47.9	10/25/25 8:00 == 48	10/25/25 12:30 == 47.9	10/25/25 17:00 == 47.8
10/25/25 3:35 == 47.8	10/25/25 8:05 == 48	10/25/25 12:35 == 47.9	10/25/25 17:05 == 47.9
10/25/25 3:40 == 47.8	10/25/25 8:10 == 47.9	10/25/25 12:40 == 47.9	10/25/25 17:10 == 47.9
10/25/25 3:45 == 47.9	10/25/25 8:15 == 48	10/25/25 12:45 == 48	10/25/25 17:15 == 47.8
10/25/25 3:50 == 47.9	10/25/25 8:20 == 47.9	10/25/25 12:50 == 48	10/25/25 17:20 == 47.9
10/25/25 3:55 == 47.3	10/25/25 8:25 == 47.9	10/25/25 12:55 == 47.9	10/25/25 17:25 == 48
10/25/25 4:00 == 47.5	10/25/25 8:30 == 48.1	10/25/25 13:00 == 47.9	10/25/25 17:30 == 48
10/25/25 4:05 == 47.9	10/25/25 8:35 == 48.1	10/25/25 13:05 == 48	10/25/25 17:35 == 48
10/25/25 4:10 == 47.9	10/25/25 8:40 == 48	10/25/25 13:10 == 48.1	10/25/25 17:40 == 48
10/25/25 4:15 == 47.9	10/25/25 8:45 == 48	10/25/25 13:15 == 47.8	10/25/25 17:45 == 47.9
10/25/25 4:20 == 47.9	10/25/25 8:50 == 48	10/25/25 13:20 == 47.7	10/25/25 17:50 == 47.8
10/25/25 4:25 == 48	10/25/25 8:55 == 48.1	10/25/25 13:25 == 47.8	10/25/25 17:55 == 46.8

Pumpback Station Discharge (0364)

10/25/25 18:00 == 47.9	10/25/25 22:30 == 47.8	10/26/25 3:00 == 47.6	10/26/25 7:30 == 48
10/25/25 18:05 == 48	10/25/25 22:35 == 47.8	10/26/25 3:05 == 47.8	10/26/25 7:35 == 47.9
10/25/25 18:10 == 47.9	10/25/25 22:40 == 47.9	10/26/25 3:10 == 47.9	10/26/25 7:40 == 47.6
10/25/25 18:15 == 48	10/25/25 22:45 == 48	10/26/25 3:15 == 47.8	10/26/25 7:45 == 47.7
10/25/25 18:20 == 48	10/25/25 22:50 == 47.9	10/26/25 3:20 == 47.8	10/26/25 7:50 == 47.9
10/25/25 18:25 == 47.6	10/25/25 22:55 == 47.8	10/26/25 3:25 == 47.8	10/26/25 7:55 == 47.9
10/25/25 18:30 == 47.8	10/25/25 23:00 == 47.5	10/26/25 3:30 == 47.7	10/26/25 8:00 == 48
10/25/25 18:35 == 47.9	10/25/25 23:05 == 48.1	10/26/25 3:35 == 47.9	10/26/25 8:05 == 48
10/25/25 18:40 == 47.9	10/25/25 23:10 == 48	10/26/25 3:40 == 48	10/26/25 8:10 == 48
10/25/25 18:45 == 47.7	10/25/25 23:15 == 47.9	10/26/25 3:45 == 47.9	10/26/25 8:15 == 47.8
10/25/25 18:50 == 48	10/25/25 23:20 == 48.2	10/26/25 3:50 == 47.8	10/26/25 8:20 == 47.6
10/25/25 18:55 == 47.8	10/25/25 23:25 == 47.8	10/26/25 3:55 == 47.4	10/26/25 8:25 == 48
10/25/25 19:00 == 47.9	10/25/25 23:30 == 48	10/26/25 4:00 == 47.9	10/26/25 8:30 == 48
10/25/25 19:05 == 48.1	10/25/25 23:35 == 47.9	10/26/25 4:05 == 47.9	10/26/25 8:35 == 48
10/25/25 19:10 == 47.8	10/25/25 23:40 == 48	10/26/25 4:10 == 47.8	10/26/25 8:40 == 47.8
10/25/25 19:15 == 47.8	10/25/25 23:45 == 48	10/26/25 4:15 == 47.7	10/26/25 8:45 == 47.8
10/25/25 19:20 == 47.8	10/25/25 23:50 == 47.5	10/26/25 4:20 == 47.8	10/26/25 8:50 == 47.9
10/25/25 19:25 == 47.9	10/25/25 23:55 == 47.7	10/26/25 4:25 == 47.9	10/26/25 8:55 == 47.8
10/25/25 19:30 == 47.9	10/26/25 0:00 == 48	10/26/25 4:30 == 48	10/26/25 9:00 == 47.8
10/25/25 19:35 == 47.9	10/26/25 0:05 == 48	10/26/25 4:35 == 47.8	10/26/25 9:05 == 48
10/25/25 19:40 == 47.7	10/26/25 0:10 == 48	10/26/25 4:40 == 47.8	10/26/25 9:10 == 48
10/25/25 19:45 == 47.7	10/26/25 0:15 == 48.1	10/26/25 4:45 == 48	10/26/25 9:15 == 47.9
10/25/25 19:50 == 48	10/26/25 0:20 == 48	10/26/25 4:50 == 47.9	10/26/25 9:20 == 47.9
10/25/25 19:55 == 48	10/26/25 0:25 == 48	10/26/25 4:55 == 48.1	10/26/25 9:25 == 48
10/25/25 20:00 == 47.8	10/26/25 0:30 == 48	10/26/25 5:00 == 48	10/26/25 9:30 == 48
10/25/25 20:05 == 47.8	10/26/25 0:35 == 47.9	10/26/25 5:05 == 48	10/26/25 9:35 == 47.9
10/25/25 20:10 == 47.7	10/26/25 0:40 == 47.9	10/26/25 5:10 == 47.9	10/26/25 9:40 == 48.1
10/25/25 20:15 == 47.9	10/26/25 0:45 == 48	10/26/25 5:15 == 48	10/26/25 9:45 == 47.9
10/25/25 20:20 == 47.9	10/26/25 0:50 == 48	10/26/25 5:20 == 48	10/26/25 9:50 == 48
10/25/25 20:25 == 47.3	10/26/25 0:55 == 47.9	10/26/25 5:25 == 47.5	10/26/25 9:55 == 47.9
10/25/25 20:30 == 47.8	10/26/25 1:00 == 47.8	10/26/25 5:30 == 47.6	10/26/25 10:00 == 47.9
10/25/25 20:35 == 47.9	10/26/25 1:05 == 47.7	10/26/25 5:35 == 47.9	10/26/25 10:05 == 47.9
10/25/25 20:40 == 47.6	10/26/25 1:10 == 47.7	10/26/25 5:40 == 47.9	10/26/25 10:10 == 47.9
10/25/25 20:45 == 48	10/26/25 1:15 == 47.9	10/26/25 5:45 == 47.8	10/26/25 10:15 == 47.7
10/25/25 20:50 == 48.1	10/26/25 1:20 == 47.9	10/26/25 5:50 == 47.8	10/26/25 10:20 == 47.8
10/25/25 20:55 == 47.6	10/26/25 1:25 == 47.9	10/26/25 5:55 == 44.7	10/26/25 10:25 == 47.9
10/25/25 21:00 == 47.4	10/26/25 1:30 == 47.8	10/26/25 6:00 == 41.6	10/26/25 10:30 == 47.6
10/25/25 21:05 == 47.9	10/26/25 1:35 == 47.9	10/26/25 6:05 == 2.9	10/26/25 10:35 == 47.5
10/25/25 21:10 == 47.6	10/26/25 1:40 == 47.8	10/26/25 6:10 == 0.7	10/26/25 10:40 == 47.9
10/25/25 21:15 == 47.8	10/26/25 1:45 == 48	10/26/25 6:15 == 11.2	10/26/25 10:45 == 48
10/25/25 21:20 == 47.8	10/26/25 1:50 == 48	10/26/25 6:20 == 16.3	10/26/25 10:50 == 48
10/25/25 21:25 == 47.4	10/26/25 1:55 == 47.8	10/26/25 6:25 == 35.1	10/26/25 10:55 == 48.1
10/25/25 21:30 == 47.8	10/26/25 2:00 == 47.6	10/26/25 6:30 == 47.6	10/26/25 11:00 == 48.1
10/25/25 21:35 == 47.9	10/26/25 2:05 == 48.1	10/26/25 6:35 == 48	10/26/25 11:05 == 47.6
10/25/25 21:40 == 47.9	10/26/25 2:10 == 47.9	10/26/25 6:40 == 47.9	10/26/25 11:10 == 47
10/25/25 21:45 == 48	10/26/25 2:15 == 47.9	10/26/25 6:45 == 47.9	10/26/25 11:15 == 48
10/25/25 21:50 == 48	10/26/25 2:20 == 47.8	10/26/25 6:50 == 48	10/26/25 11:20 == 48
10/25/25 21:55 == 48	10/26/25 2:25 == 47.3	10/26/25 6:55 == 47.9	10/26/25 11:25 == 47.5
10/25/25 22:00 == 47.8	10/26/25 2:30 == 47.7	10/26/25 7:00 == 47.9	10/26/25 11:30 == 48
10/25/25 22:05 == 47.9	10/26/25 2:35 == 47.9	10/26/25 7:05 == 48	10/26/25 11:35 == 47.8
10/25/25 22:10 == 48	10/26/25 2:40 == 47.9	10/26/25 7:10 == 47.7	10/26/25 11:40 == 48.3
10/25/25 22:15 == 48	10/26/25 2:45 == 48	10/26/25 7:15 == 47.9	10/26/25 11:45 == 48
10/25/25 22:20 == 48.1	10/26/25 2:50 == 48	10/26/25 7:20 == 48.1	10/26/25 11:50 == 48
10/25/25 22:25 == 48	10/26/25 2:55 == 47.5	10/26/25 7:25 == 48.1	10/26/25 11:55 == 47.4

Pumpback Station Discharge (0364)

10/26/25 12:00 == 47.8	10/26/25 16:30 == 48.2	10/26/25 21:00 == 48	10/27/25 1:30 == 47.7
10/26/25 12:05 == 47.9	10/26/25 16:35 == 48.1	10/26/25 21:05 == 47.9	10/27/25 1:35 == 48
10/26/25 12:10 == 47.3	10/26/25 16:40 == 48	10/26/25 21:10 == 47.8	10/27/25 1:40 == 48
10/26/25 12:15 == 47.8	10/26/25 16:45 == 47.4	10/26/25 21:15 == 47.9	10/27/25 1:45 == 48
10/26/25 12:20 == 48	10/26/25 16:50 == 47.8	10/26/25 21:20 == 47.8	10/27/25 1:50 == 47.9
10/26/25 12:25 == 48	10/26/25 16:55 == 48.1	10/26/25 21:25 == 47.9	10/27/25 1:55 == 47.7
10/26/25 12:30 == 48.1	10/26/25 17:00 == 47.9	10/26/25 21:30 == 47.9	10/27/25 2:00 == 47.7
10/26/25 12:35 == 48.1	10/26/25 17:05 == 41.3	10/26/25 21:35 == 48	10/27/25 2:05 == 47.9
10/26/25 12:40 == 48	10/26/25 17:10 == 33.8	10/26/25 21:40 == 47.9	10/27/25 2:10 == 47.9
10/26/25 12:45 == 48	10/26/25 17:15 == 32.5	10/26/25 21:45 == 47.9	10/27/25 2:15 == 47.8
10/26/25 12:50 == 48	10/26/25 17:20 == 32.6	10/26/25 21:50 == 47.9	10/27/25 2:20 == 43.3
10/26/25 12:55 == 47.8	10/26/25 17:25 == 32.5	10/26/25 21:55 == 47.8	10/27/25 2:25 == 32.9
10/26/25 13:00 == 47.8	10/26/25 17:30 == 32.5	10/26/25 22:00 == 47.7	10/27/25 2:30 == 32.5
10/26/25 13:05 == 47.9	10/26/25 17:35 == 32.6	10/26/25 22:05 == 42.2	10/27/25 2:35 == 32.5
10/26/25 13:10 == 47.8	10/26/25 17:40 == 32.7	10/26/25 22:10 == 33.2	10/27/25 2:40 == 32.7
10/26/25 13:15 == 47.8	10/26/25 17:45 == 32.7	10/26/25 22:15 == 32.6	10/27/25 2:45 == 32.5
10/26/25 13:20 == 48	10/26/25 17:50 == 38.1	10/26/25 22:20 == 32.7	10/27/25 2:50 == 32.6
10/26/25 13:25 == 48	10/26/25 17:55 == 44.7	10/26/25 22:25 == 32.6	10/27/25 2:55 == 32.5
10/26/25 13:30 == 48	10/26/25 18:00 == 47.5	10/26/25 22:30 == 32.6	10/27/25 3:00 == 32.6
10/26/25 13:35 == 48	10/26/25 18:05 == 48	10/26/25 22:35 == 32.7	10/27/25 3:05 == 33.7
10/26/25 13:40 == 48	10/26/25 18:10 == 47.9	10/26/25 22:40 == 32.5	10/27/25 3:10 == 47
10/26/25 13:45 == 47.9	10/26/25 18:15 == 48	10/26/25 22:45 == 32.6	10/27/25 3:15 == 47.8
10/26/25 13:50 == 47.9	10/26/25 18:20 == 47.8	10/26/25 22:50 == 37.4	10/27/25 3:20 == 47.9
10/26/25 13:55 == 47.9	10/26/25 18:25 == 47.3	10/26/25 22:55 == 44.4	10/27/25 3:25 == 48
10/26/25 14:00 == 48	10/26/25 18:30 == 47.4	10/26/25 23:00 == 47.5	10/27/25 3:30 == 48
10/26/25 14:05 == 48.2	10/26/25 18:35 == 47.9	10/26/25 23:05 == 48	10/27/25 3:35 == 47.9
10/26/25 14:10 == 48	10/26/25 18:40 == 47.9	10/26/25 23:10 == 47.7	10/27/25 3:40 == 48.1
10/26/25 14:15 == 47.8	10/26/25 18:45 == 48	10/26/25 23:15 == 47.7	10/27/25 3:45 == 47.9
10/26/25 14:20 == 48.2	10/26/25 18:50 == 47.7	10/26/25 23:20 == 47.9	10/27/25 3:50 == 47.9
10/26/25 14:25 == 47.9	10/26/25 18:55 == 47.2	10/26/25 23:25 == 47.9	10/27/25 3:55 == 47.3
10/26/25 14:30 == 48.1	10/26/25 19:00 == 47.4	10/26/25 23:30 == 47.9	10/27/25 4:00 == 47.7
10/26/25 14:35 == 47.8	10/26/25 19:05 == 43	10/26/25 23:35 == 47.7	10/27/25 4:05 == 48
10/26/25 14:40 == 47.9	10/26/25 19:10 == 32.5	10/26/25 23:40 == 47.6	10/27/25 4:10 == 47.6
10/26/25 14:45 == 47.9	10/26/25 19:15 == 32.5	10/26/25 23:45 == 47.8	10/27/25 4:15 == 47.7
10/26/25 14:50 == 48.1	10/26/25 19:20 == 32.6	10/26/25 23:50 == 47.7	10/27/25 4:20 == 47.8
10/26/25 14:55 == 47.9	10/26/25 19:25 == 32.6	10/26/25 23:55 == 47.6	10/27/25 4:25 == 47.8
10/26/25 15:00 == 48	10/26/25 19:30 == 32.6	10/27/25 0:00 == 47.9	10/27/25 4:30 == 47.9
10/26/25 15:05 == 48	10/26/25 19:35 == 32.6	10/27/25 0:05 == 48	10/27/25 4:35 == 42.7
10/26/25 15:10 == 47.6	10/26/25 19:40 == 32.6	10/27/25 0:10 == 48	10/27/25 4:40 == 34.6
10/26/25 15:15 == 47.8	10/26/25 19:45 == 32.5	10/27/25 0:15 == 48.1	10/27/25 4:45 == 32.6
10/26/25 15:20 == 48	10/26/25 19:50 == 36.7	10/27/25 0:20 == 47.9	10/27/25 4:50 == 32.6
10/26/25 15:25 == 47.9	10/26/25 19:55 == 45.1	10/27/25 0:25 == 48	10/27/25 4:55 == 32.5
10/26/25 15:30 == 47.9	10/26/25 20:00 == 47.8	10/27/25 0:30 == 47.9	10/27/25 5:00 == 32.6
10/26/25 15:35 == 47.8	10/26/25 20:05 == 47.9	10/27/25 0:35 == 43.7	10/27/25 5:05 == 32.7
10/26/25 15:40 == 47.6	10/26/25 20:10 == 48	10/27/25 0:40 == 32.8	10/27/25 5:10 == 32.7
10/26/25 15:45 == 47.7	10/26/25 20:15 == 48	10/27/25 0:45 == 32.6	10/27/25 5:15 == 32.6
10/26/25 15:50 == 47.7	10/26/25 20:20 == 48	10/27/25 0:50 == 32.5	10/27/25 5:20 == 34.2
10/26/25 15:55 == 47.6	10/26/25 20:25 == 47.5	10/27/25 0:55 == 32.6	10/27/25 5:25 == 45.7
10/26/25 16:00 == 47.8	10/26/25 20:30 == 47.6	10/27/25 1:00 == 32.7	10/27/25 5:30 == 47.9
10/26/25 16:05 == 47.8	10/26/25 20:35 == 47.8	10/27/25 1:05 == 36	10/27/25 5:35 == 47.8
10/26/25 16:10 == 47.5	10/26/25 20:40 == 47.6	10/27/25 1:10 == 44.8	10/27/25 5:40 == 47.9
10/26/25 16:15 == 48	10/26/25 20:45 == 47.7	10/27/25 1:15 == 47.8	10/27/25 5:45 == 47.9
10/26/25 16:20 == 47.9	10/26/25 20:50 == 47.8	10/27/25 1:20 == 48	10/27/25 5:50 == 47.8
10/26/25 16:25 == 47.8	10/26/25 20:55 == 47.8	10/27/25 1:25 == 47.4	10/27/25 5:55 == 48

Pumpback Station Discharge (0364)

10/27/25 6:00 == 47.9	10/27/25 10:30 == 32.6	10/27/25 15:00 == 48	10/27/25 19:30 == 32.5
10/27/25 6:05 == 47.8	10/27/25 10:35 == 32.5	10/27/25 15:05 == 47.8	10/27/25 19:35 == 34.9
10/27/25 6:10 == 47.8	10/27/25 10:40 == 32.8	10/27/25 15:10 == 47.6	10/27/25 19:40 == 43.2
10/27/25 6:15 == 47.9	10/27/25 10:45 == 32.5	10/27/25 15:15 == 47.9	10/27/25 19:45 == 47.8
10/27/25 6:20 == 48	10/27/25 10:50 == 32.5	10/27/25 15:20 == 47.9	10/27/25 19:50 == 47.9
10/27/25 6:25 == 47.8	10/27/25 10:55 == 47.5	10/27/25 15:25 == 48	10/27/25 19:55 == 47.9
10/27/25 6:30 == 47.9	10/27/25 11:00 == 47.8	10/27/25 15:30 == 48.1	10/27/25 20:00 == 47.7
10/27/25 6:35 == 42.1	10/27/25 11:05 == 47.9	10/27/25 15:35 == 45.6	10/27/25 20:05 == 47.8
10/27/25 6:40 == 35	10/27/25 11:10 == 47.4	10/27/25 15:40 == 33.9	10/27/25 20:10 == 47.9
10/27/25 6:45 == 32.6	10/27/25 11:15 == 48	10/27/25 15:45 == 32.8	10/27/25 20:15 == 48
10/27/25 6:50 == 32.6	10/27/25 11:20 == 48.1	10/27/25 15:50 == 32.8	10/27/25 20:20 == 48
10/27/25 6:55 == 32.6	10/27/25 11:25 == 47.4	10/27/25 15:55 == 33	10/27/25 20:25 == 47.8
10/27/25 7:00 == 32.6	10/27/25 11:30 == 47.7	10/27/25 16:00 == 32.8	10/27/25 20:30 == 47.8
10/27/25 7:05 == 36.5	10/27/25 11:35 == 47.9	10/27/25 16:05 == 32.8	10/27/25 20:35 == 45.4
10/27/25 7:10 == 43.6	10/27/25 11:40 == 48	10/27/25 16:10 == 32.7	10/27/25 20:40 == 35.6
10/27/25 7:15 == 47.3	10/27/25 11:45 == 47.9	10/27/25 16:15 == 32.8	10/27/25 20:45 == 32.7
10/27/25 7:20 == 47.6	10/27/25 11:50 == 48	10/27/25 16:20 == 33	10/27/25 20:50 == 32.7
10/27/25 7:25 == 47.9	10/27/25 11:55 == 47.7	10/27/25 16:25 == 45.4	10/27/25 20:55 == 32.5
10/27/25 7:30 == 48	10/27/25 12:00 == 47.8	10/27/25 16:30 == 47.7	10/27/25 21:00 == 32.7
10/27/25 7:35 == 47.9	10/27/25 12:05 == 43.2	10/27/25 16:35 == 48.1	10/27/25 21:05 == 33
10/27/25 7:40 == 47.4	10/27/25 12:10 == 35.9	10/27/25 16:40 == 47.9	10/27/25 21:10 == 43.6
10/27/25 7:45 == 47.9	10/27/25 12:15 == 32.7	10/27/25 16:45 == 47.9	10/27/25 21:15 == 47.2
10/27/25 7:50 == 47.9	10/27/25 12:20 == 32.7	10/27/25 16:50 == 48	10/27/25 21:20 == 47.9
10/27/25 7:55 == 47.8	10/27/25 12:25 == 32.7	10/27/25 16:55 == 47.9	10/27/25 21:25 == 47.9
10/27/25 8:00 == 47.7	10/27/25 12:30 == 32.8	10/27/25 17:00 == 48	10/27/25 21:30 == 48
10/27/25 8:05 == 47.9	10/27/25 12:35 == 32.7	10/27/25 17:05 == 48.1	10/27/25 21:35 == 48
10/27/25 8:10 == 48	10/27/25 12:40 == 32.6	10/27/25 17:10 == 48	10/27/25 21:40 == 47.9
10/27/25 8:15 == 48	10/27/25 12:45 == 32.7	10/27/25 17:15 == 47.9	10/27/25 21:45 == 48
10/27/25 8:20 == 45.1	10/27/25 12:50 == 35	10/27/25 17:20 == 43.4	10/27/25 21:50 == 47.9
10/27/25 8:25 == 33	10/27/25 12:55 == 43.5	10/27/25 17:25 == 35.9	10/27/25 21:55 == 47.7
10/27/25 8:30 == 32.8	10/27/25 13:00 == 47.8	10/27/25 17:30 == 32.5	10/27/25 22:00 == 47.9
10/27/25 8:35 == 32.6	10/27/25 13:05 == 48	10/27/25 17:35 == 32.6	10/27/25 22:05 == 44.1
10/27/25 8:40 == 32.4	10/27/25 13:10 == 48	10/27/25 17:40 == 32.6	10/27/25 22:10 == 36
10/27/25 8:45 == 32.5	10/27/25 13:15 == 47.9	10/27/25 17:45 == 32.6	10/27/25 22:15 == 32.5
10/27/25 8:50 == 32.6	10/27/25 13:20 == 47.9	10/27/25 17:50 == 32.7	10/27/25 22:20 == 32.7
10/27/25 8:55 == 32.5	10/27/25 13:25 == 48.1	10/27/25 17:55 == 32.9	10/27/25 22:25 == 32.7
10/27/25 9:00 == 32.6	10/27/25 13:30 == 47.9	10/27/25 18:00 == 32.7	10/27/25 22:30 == 32.5
10/27/25 9:05 == 35.5	10/27/25 13:35 == 47.9	10/27/25 18:05 == 34.5	10/27/25 22:35 == 35
10/27/25 9:10 == 43.9	10/27/25 13:40 == 47.9	10/27/25 18:10 == 43.4	10/27/25 22:40 == 42.2
10/27/25 9:15 == 47.7	10/27/25 13:45 == 48	10/27/25 18:15 == 47.7	10/27/25 22:45 == 47.9
10/27/25 9:20 == 47.9	10/27/25 13:50 == 47.9	10/27/25 18:20 == 47.9	10/27/25 22:50 == 47.9
10/27/25 9:25 == 48	10/27/25 13:55 == 48	10/27/25 18:25 == 47.7	10/27/25 22:55 == 47.9
10/27/25 9:30 == 48	10/27/25 14:00 == 48.1	10/27/25 18:30 == 47.8	10/27/25 23:00 == 48
10/27/25 9:35 == 47.9	10/27/25 14:05 == 43.6	10/27/25 18:35 == 48	10/27/25 23:05 == 48
10/27/25 9:40 == 47.8	10/27/25 14:10 == 35.1	10/27/25 18:40 == 47.9	10/27/25 23:10 == 47.9
10/27/25 9:45 == 47.8	10/27/25 14:15 == 32.6	10/27/25 18:45 == 47.8	10/27/25 23:15 == 48.1
10/27/25 9:50 == 48	10/27/25 14:20 == 32.7	10/27/25 18:50 == 47.9	10/27/25 23:20 == 47.9
10/27/25 9:55 == 47.9	10/27/25 14:25 == 32.7	10/27/25 18:55 == 47.8	10/27/25 23:25 == 47.5
10/27/25 10:00 == 48	10/27/25 14:30 == 32.7	10/27/25 19:00 == 47.9	10/27/25 23:30 == 47.7
10/27/25 10:05 == 48	10/27/25 14:35 == 35.9	10/27/25 19:05 == 44.8	10/27/25 23:35 == 47.1
10/27/25 10:10 == 47.8	10/27/25 14:40 == 43.3	10/27/25 19:10 == 34.7	10/27/25 23:40 == 34.3
10/27/25 10:15 == 47.8	10/27/25 14:45 == 47.8	10/27/25 19:15 == 32.4	10/27/25 23:45 == 32.7
10/27/25 10:20 == 44.8	10/27/25 14:50 == 47.9	10/27/25 19:20 == 32.5	10/27/25 23:50 == 32.4
10/27/25 10:25 == 32.8	10/27/25 14:55 == 47.9	10/27/25 19:25 == 32.4	10/27/25 23:55 == 32.5

Pumpback Station Discharge (0364)

10/28/25 0:00 == 32.7	10/28/25 4:30 == 47.9	10/28/25 9:00 == 32.6	10/28/25 13:30 == 48
10/28/25 0:05 == 32.6	10/28/25 4:35 == 48	10/28/25 9:05 == 32.6	10/28/25 13:35 == 48
10/28/25 0:10 == 43.9	10/28/25 4:40 == 48	10/28/25 9:10 == 32.5	10/28/25 13:40 == 47.9
10/28/25 0:15 == 47.6	10/28/25 4:45 == 48.1	10/28/25 9:15 == 32.5	10/28/25 13:45 == 48
10/28/25 0:20 == 47.9	10/28/25 4:50 == 47.6	10/28/25 9:20 == 34.3	10/28/25 13:50 == 48
10/28/25 0:25 == 47.9	10/28/25 4:55 == 34.4	10/28/25 9:25 == 40.6	10/28/25 13:55 == 48
10/28/25 0:30 == 47.9	10/28/25 5:00 == 32.6	10/28/25 9:30 == 47.5	10/28/25 14:00 == 47.9
10/28/25 0:35 == 47.9	10/28/25 5:05 == 32.6	10/28/25 9:35 == 47.8	10/28/25 14:05 == 45.3
10/28/25 0:40 == 48	10/28/25 5:10 == 32.5	10/28/25 9:40 == 48	10/28/25 14:10 == 38.4
10/28/25 0:45 == 48	10/28/25 5:15 == 32.5	10/28/25 9:45 == 48	10/28/25 14:15 == 32.8
10/28/25 0:50 == 48.1	10/28/25 5:20 == 32.5	10/28/25 9:50 == 48.1	10/28/25 14:20 == 32.8
10/28/25 0:55 == 48	10/28/25 5:25 == 32.6	10/28/25 9:55 == 47.9	10/28/25 14:25 == 32.8
10/28/25 1:00 == 48	10/28/25 5:30 == 32.6	10/28/25 10:00 == 48.1	10/28/25 14:30 == 32.7
10/28/25 1:05 == 44.3	10/28/25 5:35 == 32.7	10/28/25 10:05 == 48	10/28/25 14:35 == 32.8
10/28/25 1:10 == 36.7	10/28/25 5:40 == 43.2	10/28/25 10:10 == 48	10/28/25 14:40 == 32.8
10/28/25 1:15 == 32.5	10/28/25 5:45 == 47.7	10/28/25 10:15 == 47.9	10/28/25 14:45 == 32.8
10/28/25 1:20 == 32.6	10/28/25 5:50 == 48	10/28/25 10:20 == 48	10/28/25 14:50 == 33.9
10/28/25 1:25 == 32.6	10/28/25 5:55 == 47.6	10/28/25 10:25 == 34.6	10/28/25 14:55 == 40.8
10/28/25 1:30 == 32.5	10/28/25 6:00 == 47.7	10/28/25 10:30 == 32.7	10/28/25 15:00 == 48
10/28/25 1:35 == 32.4	10/28/25 6:05 == 48	10/28/25 10:35 == 32.6	10/28/25 15:05 == 48.1
10/28/25 1:40 == 32.4	10/28/25 6:10 == 48	10/28/25 10:40 == 32.7	10/28/25 15:10 == 47.5
10/28/25 1:45 == 32.6	10/28/25 6:15 == 47.9	10/28/25 10:45 == 32.8	10/28/25 15:15 == 48
10/28/25 1:50 == 34.2	10/28/25 6:20 == 48	10/28/25 10:50 == 32.6	10/28/25 15:20 == 47.8
10/28/25 1:55 == 42.5	10/28/25 6:25 == 48	10/28/25 10:55 == 32.6	10/28/25 15:25 == 48
10/28/25 2:00 == 47.8	10/28/25 6:30 == 47.9	10/28/25 11:00 == 32.8	10/28/25 15:30 == 48.1
10/28/25 2:05 == 48	10/28/25 6:35 == 44.7	10/28/25 11:05 == 33.5	10/28/25 15:35 == 47.6
10/28/25 2:10 == 47.8	10/28/25 6:40 == 37	10/28/25 11:10 == 42	10/28/25 15:40 == 47.1
10/28/25 2:15 == 47.9	10/28/25 6:45 == 32.6	10/28/25 11:15 == 47.9	10/28/25 15:45 == 47.6
10/28/25 2:20 == 47.9	10/28/25 6:50 == 32.6	10/28/25 11:20 == 47.9	10/28/25 15:50 == 47.7
10/28/25 2:25 == 47.4	10/28/25 6:55 == 32.5	10/28/25 11:25 == 47.7	10/28/25 15:55 == 36.8
10/28/25 2:30 == 48.1	10/28/25 7:00 == 32.5	10/28/25 11:30 == 47.8	10/28/25 16:00 == 33.1
10/28/25 2:35 == 47.8	10/28/25 7:05 == 32.5	10/28/25 11:35 == 48	10/28/25 16:05 == 33
10/28/25 2:40 == 48	10/28/25 7:10 == 32.8	10/28/25 11:40 == 48	10/28/25 16:10 == 32.8
10/28/25 2:45 == 48.1	10/28/25 7:15 == 32.7	10/28/25 11:45 == 48	10/28/25 16:15 == 32.8
10/28/25 2:50 == 47.9	10/28/25 7:20 == 33.3	10/28/25 11:50 == 47.9	10/28/25 16:20 == 32.9
10/28/25 2:55 == 47.6	10/28/25 7:25 == 42.2	10/28/25 11:55 == 47.4	10/28/25 16:25 == 32.8
10/28/25 3:00 == 47.8	10/28/25 7:30 == 47.5	10/28/25 12:00 == 47.7	10/28/25 16:30 == 32.8
10/28/25 3:05 == 45.4	10/28/25 7:35 == 47.9	10/28/25 12:05 == 47.8	10/28/25 16:35 == 33.6
10/28/25 3:10 == 36.1	10/28/25 7:40 == 47.1	10/28/25 12:10 == 47.5	10/28/25 16:40 == 40.2
10/28/25 3:15 == 32.5	10/28/25 7:45 == 47.9	10/28/25 12:15 == 47.9	10/28/25 16:45 == 47.5
10/28/25 3:20 == 32.6	10/28/25 7:50 == 48	10/28/25 12:20 == 46.9	10/28/25 16:50 == 48
10/28/25 3:25 == 32.6	10/28/25 7:55 == 47.3	10/28/25 12:25 == 37.2	10/28/25 16:55 == 47.9
10/28/25 3:30 == 32.6	10/28/25 8:00 == 47.7	10/28/25 12:30 == 33	10/28/25 17:00 == 47.7
10/28/25 3:35 == 32.6	10/28/25 8:05 == 48	10/28/25 12:35 == 33.1	10/28/25 17:05 == 48
10/28/25 3:40 == 32.5	10/28/25 8:10 == 47.4	10/28/25 12:40 == 33	10/28/25 17:10 == 47.9
10/28/25 3:45 == 32.5	10/28/25 8:15 == 47.8	10/28/25 12:45 == 33.1	10/28/25 17:15 == 47.8
10/28/25 3:50 == 34.6	10/28/25 8:20 == 46.1	10/28/25 12:50 == 33	10/28/25 17:20 == 46.3
10/28/25 3:55 == 41.3	10/28/25 8:25 == 36.8	10/28/25 12:55 == 32.7	10/28/25 17:25 == 38.1
10/28/25 4:00 == 47.6	10/28/25 8:30 == 32.4	10/28/25 13:00 == 32.8	10/28/25 17:30 == 32.6
10/28/25 4:05 == 48	10/28/25 8:35 == 32.5	10/28/25 13:05 == 32.8	10/28/25 17:35 == 32.7
10/28/25 4:10 == 48	10/28/25 8:40 == 32.6	10/28/25 13:10 == 42.1	10/28/25 17:40 == 32.6
10/28/25 4:15 == 47.9	10/28/25 8:45 == 32.6	10/28/25 13:15 == 47.1	10/28/25 17:45 == 32.7
10/28/25 4:20 == 47.8	10/28/25 8:50 == 32.6	10/28/25 13:20 == 48	10/28/25 17:50 == 32.6
10/28/25 4:25 == 47.9	10/28/25 8:55 == 32.6	10/28/25 13:25 == 47.9	10/28/25 17:55 == 33.2

Pumpback Station Discharge (0364)

10/28/25 18:00 == 32.7	10/28/25 22:30 == 32.6	10/29/25 3:00 == 32.6	10/29/25 7:30 == 46.1
10/28/25 18:05 == 32.7	10/28/25 22:35 == 33.4	10/29/25 3:05 == 32.7	10/29/25 7:35 == 48
10/28/25 18:10 == 32.8	10/28/25 22:40 == 39.1	10/29/25 3:10 == 32.6	10/29/25 7:40 == 47.4
10/28/25 18:15 == 32.5	10/28/25 22:45 == 47.3	10/29/25 3:15 == 32.6	10/29/25 7:45 == 47.6
10/28/25 18:20 == 32.7	10/28/25 22:50 == 47.8	10/29/25 3:20 == 32.6	10/29/25 7:50 == 47.9
10/28/25 18:25 == 40.4	10/28/25 22:55 == 47.9	10/29/25 3:25 == 32.6	10/29/25 7:55 == 47.8
10/28/25 18:30 == 46.5	10/28/25 23:00 == 47.9	10/29/25 3:30 == 32.6	10/29/25 8:00 == 47.9
10/28/25 18:35 == 48	10/28/25 23:05 == 48	10/29/25 3:35 == 33.3	10/29/25 8:05 == 47.4
10/28/25 18:40 == 47.5	10/28/25 23:10 == 47.4	10/29/25 3:40 == 38.1	10/29/25 8:10 == 40.5
10/28/25 18:45 == 47.7	10/28/25 23:15 == 47.8	10/29/25 3:45 == 47.9	10/29/25 8:15 == 32.7
10/28/25 18:50 == 47.9	10/28/25 23:20 == 48	10/29/25 3:50 == 48	10/29/25 8:20 == 32.6
10/28/25 18:55 == 47.8	10/28/25 23:25 == 47.9	10/29/25 3:55 == 47.4	10/29/25 8:25 == 32.7
10/28/25 19:00 == 47.9	10/28/25 23:30 == 47.7	10/29/25 4:00 == 47.7	10/29/25 8:30 == 32.6
10/28/25 19:05 == 48	10/28/25 23:35 == 47.7	10/29/25 4:05 == 48	10/29/25 8:35 == 32.7
10/28/25 19:10 == 47.9	10/28/25 23:40 == 37.7	10/29/25 4:10 == 48.2	10/29/25 8:40 == 32.6
10/28/25 19:15 == 47.9	10/28/25 23:45 == 33.1	10/29/25 4:15 == 48.1	10/29/25 8:45 == 32.5
10/28/25 19:20 == 47.9	10/28/25 23:50 == 32.6	10/29/25 4:20 == 48	10/29/25 8:50 == 33
10/28/25 19:25 == 47.8	10/28/25 23:55 == 32.6	10/29/25 4:25 == 47.6	10/29/25 8:55 == 36.9
10/28/25 19:30 == 47.9	10/29/25 0:00 == 32.7	10/29/25 4:30 == 47.8	10/29/25 9:00 == 47.8
10/28/25 19:35 == 47.9	10/29/25 0:05 == 32.8	10/29/25 4:35 == 48.2	10/29/25 9:05 == 47.9
10/28/25 19:40 == 47.8	10/29/25 0:10 == 32.7	10/29/25 4:40 == 38.2	10/29/25 9:10 == 47.8
10/28/25 19:45 == 47.8	10/29/25 0:15 == 32.7	10/29/25 4:45 == 33.3	10/29/25 9:15 == 48.1
10/28/25 19:50 == 46.1	10/29/25 0:20 == 32.9	10/29/25 4:50 == 32.6	10/29/25 9:20 == 48
10/28/25 19:55 == 38.8	10/29/25 0:25 == 39.3	10/29/25 4:55 == 32.6	10/29/25 9:25 == 48
10/28/25 20:00 == 32.5	10/29/25 0:30 == 47.3	10/29/25 5:00 == 32.5	10/29/25 9:30 == 48
10/28/25 20:05 == 32.5	10/29/25 0:35 == 47.9	10/29/25 5:05 == 32.8	10/29/25 9:35 == 47.9
10/28/25 20:10 == 32.6	10/29/25 0:40 == 48.1	10/29/25 5:10 == 32.8	10/29/25 9:40 == 38.7
10/28/25 20:15 == 32.5	10/29/25 0:45 == 48.1	10/29/25 5:15 == 32.6	10/29/25 9:45 == 33.5
10/28/25 20:20 == 32.4	10/29/25 0:50 == 48.1	10/29/25 5:20 == 32.6	10/29/25 9:50 == 32.6
10/28/25 20:25 == 32.6	10/29/25 0:55 == 48.1	10/29/25 5:25 == 32.6	10/29/25 9:55 == 32.6
10/28/25 20:30 == 32.7	10/29/25 1:00 == 48.1	10/29/25 5:30 == 32.5	10/29/25 10:00 == 32.6
10/28/25 20:35 == 32.6	10/29/25 1:05 == 46.6	10/29/25 5:35 == 32.6	10/29/25 10:05 == 32.6
10/28/25 20:40 == 40.6	10/29/25 1:10 == 39.1	10/29/25 5:40 == 38	10/29/25 10:10 == 32.5
10/28/25 20:45 == 46.9	10/29/25 1:15 == 32.7	10/29/25 5:45 == 46.5	10/29/25 10:15 == 32.6
10/28/25 20:50 == 48	10/29/25 1:20 == 32.8	10/29/25 5:50 == 47.9	10/29/25 10:20 == 32.6
10/28/25 20:55 == 47.6	10/29/25 1:25 == 32.8	10/29/25 5:55 == 47.5	10/29/25 10:25 == 39.4
10/28/25 21:00 == 47.8	10/29/25 1:30 == 32.5	10/29/25 6:00 == 47.9	10/29/25 10:30 == 46.4
10/28/25 21:05 == 47.8	10/29/25 1:35 == 32.5	10/29/25 6:05 == 47.9	10/29/25 10:35 == 48
10/28/25 21:10 == 47.8	10/29/25 1:40 == 32.6	10/29/25 6:10 == 47.9	10/29/25 10:40 == 47.8
10/28/25 21:15 == 47.8	10/29/25 1:45 == 32.6	10/29/25 6:15 == 48.1	10/29/25 10:45 == 47.4
10/28/25 21:20 == 48	10/29/25 1:50 == 32.6	10/29/25 6:20 == 47.9	10/29/25 10:50 == 47.2
10/28/25 21:25 == 47.9	10/29/25 1:55 == 40.4	10/29/25 6:25 == 48	10/29/25 10:55 == 47.5
10/28/25 21:30 == 47.8	10/29/25 2:00 == 46.9	10/29/25 6:30 == 48.1	10/29/25 11:00 == 47.9
10/28/25 21:35 == 46.4	10/29/25 2:05 == 47.9	10/29/25 6:35 == 47.6	10/29/25 11:05 == 47.9
10/28/25 21:40 == 38.6	10/29/25 2:10 == 47.9	10/29/25 6:40 == 39.1	10/29/25 11:10 == 47.6
10/28/25 21:45 == 32.5	10/29/25 2:15 == 48	10/29/25 6:45 == 32.7	10/29/25 11:15 == 47.8
10/28/25 21:50 == 32.6	10/29/25 2:20 == 48	10/29/25 6:50 == 32.6	10/29/25 11:20 == 47
10/28/25 21:55 == 32.6	10/29/25 2:25 == 47.5	10/29/25 6:55 == 32.6	10/29/25 11:25 == 41.4
10/28/25 22:00 == 32.5	10/29/25 2:30 == 47.7	10/29/25 7:00 == 32.7	10/29/25 11:30 == 33.2
10/28/25 22:05 == 32.6	10/29/25 2:35 == 48	10/29/25 7:05 == 32.6	10/29/25 11:35 == 33.3
10/28/25 22:10 == 32.7	10/29/25 2:40 == 48	10/29/25 7:10 == 32.7	10/29/25 11:40 == 33.3
10/28/25 22:15 == 32.7	10/29/25 2:45 == 48	10/29/25 7:15 == 32.7	10/29/25 11:45 == 33
10/28/25 22:20 == 32.6	10/29/25 2:50 == 46.8	10/29/25 7:20 == 32.7	10/29/25 11:50 == 33.2
10/28/25 22:25 == 32.6	10/29/25 2:55 == 39.3	10/29/25 7:25 == 39.7	10/29/25 11:55 == 32.9

Pumpback Station Discharge (0364)

10/29/25 12:00 == 32.8	10/29/25 16:30 == 32.8	10/29/25 21:00 == 47.5	10/30/25 1:30 == 47.6
10/29/25 12:05 == 32.8	10/29/25 16:35 == 32.7	10/29/25 21:05 == 47.8	10/30/25 1:35 == 47.8
10/29/25 12:10 == 38.4	10/29/25 16:40 == 32.8	10/29/25 21:10 == 41.7	10/30/25 1:40 == 40.9
10/29/25 12:15 == 46.7	10/29/25 16:45 == 32.7	10/29/25 21:15 == 32.6	10/30/25 1:45 == 34.3
10/29/25 12:20 == 48.1	10/29/25 16:50 == 32.8	10/29/25 21:20 == 32.4	10/30/25 1:50 == 32.7
10/29/25 12:25 == 47.4	10/29/25 16:55 == 35.6	10/29/25 21:25 == 32.5	10/30/25 1:55 == 32.6
10/29/25 12:30 == 47.8	10/29/25 17:00 == 48.1	10/29/25 21:30 == 32.6	10/30/25 2:00 == 32.5
10/29/25 12:35 == 48	10/29/25 17:05 == 48	10/29/25 21:35 == 32.6	10/30/25 2:05 == 32.4
10/29/25 12:40 == 48	10/29/25 17:10 == 48	10/29/25 21:40 == 32.5	10/30/25 2:10 == 32.5
10/29/25 12:45 == 48	10/29/25 17:15 == 47.9	10/29/25 21:45 == 32.6	10/30/25 2:15 == 32.5
10/29/25 12:50 == 48.1	10/29/25 17:20 == 48	10/29/25 21:50 == 32.8	10/30/25 2:20 == 32.7
10/29/25 12:55 == 39.9	10/29/25 17:25 == 40	10/29/25 21:55 == 35.3	10/30/25 2:25 == 37.1
10/29/25 13:00 == 33.7	10/29/25 17:30 == 33.7	10/29/25 22:00 == 48	10/30/25 2:30 == 45.3
10/29/25 13:05 == 33	10/29/25 17:35 == 32.5	10/29/25 22:05 == 48	10/30/25 2:35 == 47.9
10/29/25 13:10 == 32.9	10/29/25 17:40 == 32.6	10/29/25 22:10 == 47.4	10/30/25 2:40 == 48.1
10/29/25 13:15 == 32.9	10/29/25 17:45 == 32.7	10/29/25 22:15 == 47.8	10/30/25 2:45 == 48
10/29/25 13:20 == 32.9	10/29/25 17:50 == 32.9	10/29/25 22:20 == 48	10/30/25 2:50 == 47.9
10/29/25 13:25 == 32.7	10/29/25 17:55 == 32.9	10/29/25 22:25 == 47.9	10/30/25 2:55 == 47.8
10/29/25 13:30 == 32.6	10/29/25 18:00 == 32.8	10/29/25 22:30 == 47.8	10/30/25 3:00 == 48
10/29/25 13:35 == 32.6	10/29/25 18:05 == 32.8	10/29/25 22:35 == 47.9	10/30/25 3:05 == 47.7
10/29/25 13:40 == 37.2	10/29/25 18:10 == 32.7	10/29/25 22:40 == 40.8	10/30/25 3:10 == 44
10/29/25 13:45 == 47.6	10/29/25 18:15 == 32.6	10/29/25 22:45 == 33.9	10/30/25 3:15 == 32.3
10/29/25 13:50 == 48.1	10/29/25 18:20 == 32.6	10/29/25 22:50 == 32.5	10/30/25 3:20 == 32.6
10/29/25 13:55 == 48.1	10/29/25 18:25 == 38.1	10/29/25 22:55 == 32.6	10/30/25 3:25 == 32.8
10/29/25 14:00 == 48	10/29/25 18:30 == 46	10/29/25 23:00 == 32.6	10/30/25 3:30 == 32.6
10/29/25 14:05 == 47.9	10/29/25 18:35 == 48	10/29/25 23:05 == 32.6	10/30/25 3:35 == 32.6
10/29/25 14:10 == 48	10/29/25 18:40 == 48	10/29/25 23:10 == 32.5	10/30/25 3:40 == 32.6
10/29/25 14:15 == 48	10/29/25 18:45 == 48.1	10/29/25 23:15 == 32.5	10/30/25 3:45 == 32.6
10/29/25 14:20 == 48	10/29/25 18:50 == 48	10/29/25 23:20 == 32.6	10/30/25 3:50 == 32.6
10/29/25 14:25 == 48	10/29/25 18:55 == 48	10/29/25 23:25 == 37.6	10/30/25 3:55 == 36.1
10/29/25 14:30 == 47.4	10/29/25 19:00 == 47.9	10/29/25 23:30 == 44.6	10/30/25 4:00 == 45.6
10/29/25 14:35 == 48.1	10/29/25 19:05 == 47.9	10/29/25 23:35 == 47.6	10/30/25 4:05 == 48.1
10/29/25 14:40 == 39.9	10/29/25 19:10 == 47.9	10/29/25 23:40 == 47.8	10/30/25 4:10 == 47.9
10/29/25 14:45 == 33.4	10/29/25 19:15 == 47.8	10/29/25 23:45 == 47.7	10/30/25 4:15 == 48
10/29/25 14:50 == 32.8	10/29/25 19:20 == 47.3	10/29/25 23:50 == 47.6	10/30/25 4:20 == 48
10/29/25 14:55 == 32.8	10/29/25 19:25 == 42.1	10/29/25 23:55 == 47.6	10/30/25 4:25 == 47.8
10/29/25 15:00 == 32.9	10/29/25 19:30 == 32.5	10/30/25 0:00 == 47.8	10/30/25 4:30 == 47.8
10/29/25 15:05 == 32.8	10/29/25 19:35 == 32.6	10/30/25 0:05 == 47.4	10/30/25 4:35 == 48
10/29/25 15:10 == 32.9	10/29/25 19:40 == 32.5	10/30/25 0:10 == 42.9	10/30/25 4:40 == 42
10/29/25 15:15 == 32.6	10/29/25 19:45 == 32.6	10/30/25 0:15 == 32.7	10/30/25 4:45 == 34.3
10/29/25 15:20 == 32.6	10/29/25 19:50 == 32.6	10/30/25 0:20 == 32.6	10/30/25 4:50 == 32.6
10/29/25 15:25 == 38.2	10/29/25 19:55 == 32.6	10/30/25 0:25 == 32.6	10/30/25 4:55 == 32.7
10/29/25 15:30 == 44.9	10/29/25 20:00 == 32.6	10/30/25 0:30 == 32.7	10/30/25 5:00 == 32.6
10/29/25 15:35 == 47.5	10/29/25 20:05 == 32.6	10/30/25 0:35 == 32.6	10/30/25 5:05 == 32.6
10/29/25 15:40 == 47.3	10/29/25 20:10 == 37.3	10/30/25 0:40 == 32.7	10/30/25 5:10 == 32.6
10/29/25 15:45 == 47.6	10/29/25 20:15 == 45.8	10/30/25 0:45 == 32.7	10/30/25 5:15 == 32.5
10/29/25 15:50 == 47.8	10/29/25 20:20 == 48	10/30/25 0:50 == 32.6	10/30/25 5:20 == 32.5
10/29/25 15:55 == 47.5	10/29/25 20:25 == 47.3	10/30/25 0:55 == 35.1	10/30/25 5:25 == 32.6
10/29/25 16:00 == 47.7	10/29/25 20:30 == 47.6	10/30/25 1:00 == 46.7	10/30/25 5:30 == 32.6
10/29/25 16:05 == 47.3	10/29/25 20:35 == 48	10/30/25 1:05 == 47.9	10/30/25 5:35 == 32.7
10/29/25 16:10 == 41.8	10/29/25 20:40 == 47.5	10/30/25 1:10 == 47.7	10/30/25 5:40 == 34.1
10/29/25 16:15 == 32.8	10/29/25 20:45 == 47.7	10/30/25 1:15 == 47.9	10/30/25 5:45 == 46.7
10/29/25 16:20 == 32.7	10/29/25 20:50 == 47.9	10/30/25 1:20 == 48	10/30/25 5:50 == 47.9
10/29/25 16:25 == 32.8	10/29/25 20:55 == 47.5	10/30/25 1:25 == 47.6	10/30/25 5:55 == 47.4

Pumpback Station Discharge (0364)

10/30/25 6:00 == 48	10/30/25 10:30 == 32.6	10/30/25 15:00 == 47.9	10/30/25 19:30 == 35.1
10/30/25 6:05 == 47.9	10/30/25 10:35 == 32.6	10/30/25 15:05 == 47.7	10/30/25 19:35 == 32.5
10/30/25 6:10 == 47.7	10/30/25 10:40 == 32.7	10/30/25 15:10 == 47.6	10/30/25 19:40 == 32.4
10/30/25 6:15 == 47.9	10/30/25 10:45 == 32.7	10/30/25 15:15 == 47.8	10/30/25 19:45 == 32.6
10/30/25 6:20 == 47.8	10/30/25 10:50 == 32.6	10/30/25 15:20 == 48	10/30/25 19:50 == 32.8
10/30/25 6:25 == 41.9	10/30/25 10:55 == 33.6	10/30/25 15:25 == 43.9	10/30/25 19:55 == 32.5
10/30/25 6:30 == 34.2	10/30/25 11:00 == 46.4	10/30/25 15:30 == 34.9	10/30/25 20:00 == 32.4
10/30/25 6:35 == 32.6	10/30/25 11:05 == 48	10/30/25 15:35 == 32.7	10/30/25 20:05 == 32.5
10/30/25 6:40 == 32.5	10/30/25 11:10 == 47.3	10/30/25 15:40 == 32.8	10/30/25 20:10 == 35.4
10/30/25 6:45 == 32.6	10/30/25 11:15 == 47.8	10/30/25 15:45 == 33	10/30/25 20:15 == 42.6
10/30/25 6:50 == 32.7	10/30/25 11:20 == 48	10/30/25 15:50 == 32.9	10/30/25 20:20 == 47.8
10/30/25 6:55 == 32.6	10/30/25 11:25 == 47.3	10/30/25 15:55 == 32.9	10/30/25 20:25 == 47.5
10/30/25 7:00 == 32.6	10/30/25 11:30 == 47.9	10/30/25 16:00 == 33	10/30/25 20:30 == 47.5
10/30/25 7:05 == 32.8	10/30/25 11:35 == 48	10/30/25 16:05 == 33.1	10/30/25 20:35 == 47.8
10/30/25 7:10 == 36.9	10/30/25 11:40 == 48	10/30/25 16:10 == 32.8	10/30/25 20:40 == 47.5
10/30/25 7:15 == 44	10/30/25 11:45 == 48	10/30/25 16:15 == 32.8	10/30/25 20:45 == 47.9
10/30/25 7:20 == 47.7	10/30/25 11:50 == 48.1	10/30/25 16:20 == 32.9	10/30/25 20:50 == 47.8
10/30/25 7:25 == 48	10/30/25 11:55 == 42.6	10/30/25 16:25 == 32.8	10/30/25 20:55 == 44.9
10/30/25 7:30 == 48	10/30/25 12:00 == 35.2	10/30/25 16:30 == 46.8	10/30/25 21:00 == 34
10/30/25 7:35 == 47.8	10/30/25 12:05 == 32.8	10/30/25 16:35 == 47.9	10/30/25 21:05 == 32.5
10/30/25 7:40 == 47.5	10/30/25 12:10 == 32.8	10/30/25 16:40 == 47.9	10/30/25 21:10 == 32.4
10/30/25 7:45 == 47.8	10/30/25 12:15 == 32.8	10/30/25 16:45 == 48	10/30/25 21:15 == 32.5
10/30/25 7:50 == 47.9	10/30/25 12:20 == 32.9	10/30/25 16:50 == 47.9	10/30/25 21:20 == 32.5
10/30/25 7:55 == 47.7	10/30/25 12:25 == 32.9	10/30/25 16:55 == 47.9	10/30/25 21:25 == 32.5
10/30/25 8:00 == 47.9	10/30/25 12:30 == 32.9	10/30/25 17:00 == 48	10/30/25 21:30 == 32.5
10/30/25 8:05 == 47.8	10/30/25 12:35 == 32.8	10/30/25 17:05 == 48	10/30/25 21:35 == 32.6
10/30/25 8:10 == 44.8	10/30/25 12:40 == 32.8	10/30/25 17:10 == 43.1	10/30/25 21:40 == 32.6
10/30/25 8:15 == 32.7	10/30/25 12:45 == 32.8	10/30/25 17:15 == 35.4	10/30/25 21:45 == 32.7
10/30/25 8:20 == 32.5	10/30/25 12:50 == 32.8	10/30/25 17:20 == 32.7	10/30/25 21:50 == 32.5
10/30/25 8:25 == 32.5	10/30/25 12:55 == 35.9	10/30/25 17:25 == 32.7	10/30/25 21:55 == 32.6
10/30/25 8:30 == 32.5	10/30/25 13:00 == 44.3	10/30/25 17:30 == 32.6	10/30/25 22:00 == 44.2
10/30/25 8:35 == 32.4	10/30/25 13:05 == 47.8	10/30/25 17:35 == 32.7	10/30/25 22:05 == 47.9
10/30/25 8:40 == 32.5	10/30/25 13:10 == 47.8	10/30/25 17:40 == 32.8	10/30/25 22:10 == 47.9
10/30/25 8:45 == 32.5	10/30/25 13:15 == 48	10/30/25 17:45 == 32.8	10/30/25 22:15 == 47.8
10/30/25 8:50 == 32.6	10/30/25 13:20 == 48	10/30/25 17:50 == 32.8	10/30/25 22:20 == 47.8
10/30/25 8:55 == 32.5	10/30/25 13:25 == 47.8	10/30/25 17:55 == 32.9	10/30/25 22:25 == 48
10/30/25 9:00 == 32.5	10/30/25 13:30 == 47.9	10/30/25 18:00 == 32.7	10/30/25 22:30 == 48
10/30/25 9:05 == 32.4	10/30/25 13:35 == 47.8	10/30/25 18:05 == 32.7	10/30/25 22:35 == 48.1
10/30/25 9:10 == 35.7	10/30/25 13:40 == 45.3	10/30/25 18:10 == 32.8	10/30/25 22:40 == 43.6
10/30/25 9:15 == 45	10/30/25 13:45 == 32.7	10/30/25 18:15 == 32.6	10/30/25 22:45 == 36.1
10/30/25 9:20 == 47.9	10/30/25 13:50 == 32.6	10/30/25 18:20 == 32.5	10/30/25 22:50 == 32.6
10/30/25 9:25 == 47.9	10/30/25 13:55 == 32.6	10/30/25 18:25 == 34.1	10/30/25 22:55 == 32.6
10/30/25 9:30 == 48	10/30/25 14:00 == 32.7	10/30/25 18:30 == 43.8	10/30/25 23:00 == 32.6
10/30/25 9:35 == 48	10/30/25 14:05 == 32.7	10/30/25 18:35 == 47.7	10/30/25 23:05 == 32.7
10/30/25 9:40 == 47.9	10/30/25 14:10 == 32.6	10/30/25 18:40 == 47.9	10/30/25 23:10 == 32.8
10/30/25 9:45 == 47.9	10/30/25 14:15 == 32.6	10/30/25 18:45 == 47.9	10/30/25 23:15 == 32.8
10/30/25 9:50 == 48	10/30/25 14:20 == 32.7	10/30/25 18:50 == 48.1	10/30/25 23:20 == 32.9
10/30/25 9:55 == 42.4	10/30/25 14:25 == 35.5	10/30/25 18:55 == 48	10/30/25 23:25 == 35
10/30/25 10:00 == 34.5	10/30/25 14:30 == 44.3	10/30/25 19:00 == 48	10/30/25 23:30 == 43.4
10/30/25 10:05 == 32.6	10/30/25 14:35 == 47.9	10/30/25 19:05 == 48	10/30/25 23:35 == 47.9
10/30/25 10:10 == 32.5	10/30/25 14:40 == 48	10/30/25 19:10 == 47.9	10/30/25 23:40 == 47.9
10/30/25 10:15 == 32.5	10/30/25 14:45 == 48	10/30/25 19:15 == 48.1	10/30/25 23:45 == 48
10/30/25 10:20 == 32.6	10/30/25 14:50 == 47.9	10/30/25 19:20 == 48	10/30/25 23:50 == 47.4
10/30/25 10:25 == 32.6	10/30/25 14:55 == 47.9	10/30/25 19:25 == 44.4	10/30/25 23:55 == 47.9

Pumpback Station Discharge (0364)

10/31/25 0:00 == 47.9	10/31/25 4:30 == 41.9	10/31/25 9:00 == 32.5	10/31/25 13:30 == 48
10/31/25 0:05 == 47.9	10/31/25 4:35 == 47.9	10/31/25 9:05 == 32.5	10/31/25 13:35 == 48
10/31/25 0:10 == 46.2	10/31/25 4:40 == 48	10/31/25 9:10 == 32.5	10/31/25 13:40 == 46.2
10/31/25 0:15 == 33.9	10/31/25 4:45 == 48.1	10/31/25 9:15 == 32.4	10/31/25 13:45 == 36.7
10/31/25 0:20 == 32.9	10/31/25 4:50 == 48.1	10/31/25 9:20 == 32.5	10/31/25 13:50 == 32.7
10/31/25 0:25 == 32.8	10/31/25 4:55 == 48	10/31/25 9:25 == 34.5	10/31/25 13:55 == 32.8
10/31/25 0:30 == 32.7	10/31/25 5:00 == 47.9	10/31/25 9:30 == 41.4	10/31/25 14:00 == 32.7
10/31/25 0:35 == 32.9	10/31/25 5:05 == 47.9	10/31/25 9:35 == 48.1	10/31/25 14:05 == 32.6
10/31/25 0:40 == 32.8	10/31/25 5:10 == 47.4	10/31/25 9:40 == 48.1	10/31/25 14:10 == 32.5
10/31/25 0:45 == 32.7	10/31/25 5:15 == 32.9	10/31/25 9:45 == 48	10/31/25 14:15 == 32.6
10/31/25 0:50 == 32.8	10/31/25 5:20 == 32.4	10/31/25 9:50 == 48	10/31/25 14:20 == 32.7
10/31/25 0:55 == 34.3	10/31/25 5:25 == 32.5	10/31/25 9:55 == 47.9	10/31/25 14:25 == 34.1
10/31/25 1:00 == 42.7	10/31/25 5:30 == 32.5	10/31/25 10:00 == 48	10/31/25 14:30 == 40.7
10/31/25 1:05 == 47.6	10/31/25 5:35 == 32.5	10/31/25 10:05 == 47.8	10/31/25 14:35 == 48
10/31/25 1:10 == 47.8	10/31/25 5:40 == 32.3	10/31/25 10:10 == 48	10/31/25 14:40 == 48
10/31/25 1:15 == 47.5	10/31/25 5:45 == 32.4	10/31/25 10:15 == 47.8	10/31/25 14:45 == 48.1
10/31/25 1:20 == 47.7	10/31/25 5:50 == 32.5	10/31/25 10:20 == 47.9	10/31/25 14:50 == 48.1
10/31/25 1:25 == 47.4	10/31/25 5:55 == 32.5	10/31/25 10:25 == 47.8	10/31/25 14:55 == 48
10/31/25 1:30 == 47.2	10/31/25 6:00 == 32.7	10/31/25 10:30 == 34.1	10/31/25 15:00 == 48.1
10/31/25 1:35 == 47.8	10/31/25 6:05 == 32.8	10/31/25 10:35 == 32.5	10/31/25 15:05 == 48.1
10/31/25 1:40 == 44	10/31/25 6:10 == 34	10/31/25 10:40 == 32.5	10/31/25 15:10 == 46.2
10/31/25 1:45 == 35.8	10/31/25 6:15 == 42.6	10/31/25 10:45 == 32.7	10/31/25 15:15 == 37.1
10/31/25 1:50 == 32.6	10/31/25 6:20 == 47.8	10/31/25 10:50 == 32.6	10/31/25 15:20 == 32.8
10/31/25 1:55 == 32.5	10/31/25 6:25 == 47.9	10/31/25 10:55 == 32.7	10/31/25 15:25 == 32.7
10/31/25 2:00 == 32.4	10/31/25 6:30 == 48	10/31/25 11:00 == 32.6	10/31/25 15:30 == 32.8
10/31/25 2:05 == 32.4	10/31/25 6:35 == 47.9	10/31/25 11:05 == 32.7	10/31/25 15:35 == 32.9
10/31/25 2:10 == 32.5	10/31/25 6:40 == 47.6	10/31/25 11:10 == 33.2	10/31/25 15:40 == 33
10/31/25 2:15 == 32.5	10/31/25 6:45 == 47.6	10/31/25 11:15 == 42.3	10/31/25 15:45 == 32.9
10/31/25 2:20 == 32.6	10/31/25 6:50 == 47.9	10/31/25 11:20 == 47.7	10/31/25 15:50 == 33
10/31/25 2:25 == 33.5	10/31/25 6:55 == 44.8	10/31/25 11:25 == 47.6	10/31/25 15:55 == 33.2
10/31/25 2:30 == 44.4	10/31/25 7:00 == 36.7	10/31/25 11:30 == 47.8	10/31/25 16:00 == 33.2
10/31/25 2:35 == 48.1	10/31/25 7:05 == 32.6	10/31/25 11:35 == 48.1	10/31/25 16:05 == 33.1
10/31/25 2:40 == 47.9	10/31/25 7:10 == 32.8	10/31/25 11:40 == 48.1	10/31/25 16:10 == 32.9
10/31/25 2:45 == 48	10/31/25 7:15 == 32.6	10/31/25 11:45 == 48	10/31/25 16:15 == 42
10/31/25 2:50 == 47.9	10/31/25 7:20 == 32.6	10/31/25 11:50 == 47.9	10/31/25 16:20 == 47.2
10/31/25 2:55 == 47.4	10/31/25 7:25 == 32.6	10/31/25 11:55 == 45	10/31/25 16:25 == 47.9
10/31/25 3:00 == 47.9	10/31/25 7:30 == 32.5	10/31/25 12:00 == 37.7	10/31/25 16:30 == 48
10/31/25 3:05 == 47.8	10/31/25 7:35 == 32.5	10/31/25 12:05 == 32.8	10/31/25 16:35 == 48
10/31/25 3:10 == 47.8	10/31/25 7:40 == 32.9	10/31/25 12:10 == 32.7	10/31/25 16:40 == 47.9
10/31/25 3:15 == 47.8	10/31/25 7:45 == 32.8	10/31/25 12:15 == 32.9	10/31/25 16:45 == 47.8
10/31/25 3:20 == 47.8	10/31/25 7:50 == 32.8	10/31/25 12:20 == 33	10/31/25 16:50 == 47.9
10/31/25 3:25 == 44.8	10/31/25 7:55 == 32.6	10/31/25 12:25 == 32.9	10/31/25 16:55 == 45
10/31/25 3:30 == 36.2	10/31/25 8:00 == 43.4	10/31/25 12:30 == 33	10/31/25 17:00 == 37.8
10/31/25 3:35 == 32.6	10/31/25 8:05 == 47.3	10/31/25 12:35 == 32.9	10/31/25 17:05 == 32.6
10/31/25 3:40 == 32.6	10/31/25 8:10 == 47.9	10/31/25 12:40 == 32.8	10/31/25 17:10 == 32.7
10/31/25 3:45 == 32.5	10/31/25 8:15 == 47.9	10/31/25 12:45 == 32.8	10/31/25 17:15 == 32.7
10/31/25 3:50 == 32.6	10/31/25 8:20 == 48	10/31/25 12:50 == 32.9	10/31/25 17:20 == 32.5
10/31/25 3:55 == 32.5	10/31/25 8:25 == 48	10/31/25 12:55 == 32.9	10/31/25 17:25 == 32.6
10/31/25 4:00 == 32.5	10/31/25 8:30 == 48.1	10/31/25 13:00 == 43	10/31/25 17:30 == 32.7
10/31/25 4:05 == 32.7	10/31/25 8:35 == 47.9	10/31/25 13:05 == 47.6	10/31/25 17:35 == 32.6
10/31/25 4:10 == 32.7	10/31/25 8:40 == 44.9	10/31/25 13:10 == 48.1	10/31/25 17:40 == 32.7
10/31/25 4:15 == 32.7	10/31/25 8:45 == 36.5	10/31/25 13:15 == 48	10/31/25 17:45 == 32.5
10/31/25 4:20 == 32.5	10/31/25 8:50 == 32.5	10/31/25 13:20 == 48	10/31/25 17:50 == 32.5
10/31/25 4:25 == 34.6	10/31/25 8:55 == 32.5	10/31/25 13:25 == 48.1	10/31/25 17:55 == 33

Pumpback Station Discharge (0364)

10/31/25 18:00 == 32.8	10/31/25 22:30 == 39.1
10/31/25 18:05 == 32.7	10/31/25 22:35 == 32.5
10/31/25 18:10 == 32.9	10/31/25 22:40 == 32.5
10/31/25 18:15 == 42.3	10/31/25 22:45 == 32.6
10/31/25 18:20 == 47.4	10/31/25 22:50 == 32.5
10/31/25 18:25 == 47.6	10/31/25 22:55 == 32.5
10/31/25 18:30 == 47.9	10/31/25 23:00 == 32.6
10/31/25 18:35 == 47.9	10/31/25 23:05 == 32.5
10/31/25 18:40 == 47.8	10/31/25 23:10 == 32.8
10/31/25 18:45 == 47.9	10/31/25 23:15 == 40.3
10/31/25 18:50 == 47.9	10/31/25 23:20 == 47.4
10/31/25 18:55 == 46.1	10/31/25 23:25 == 47.9
10/31/25 19:00 == 37	10/31/25 23:30 == 47.8
10/31/25 19:05 == 32.5	10/31/25 23:35 == 47.9
10/31/25 19:10 == 32.4	10/31/25 23:40 == 47.3
10/31/25 19:15 == 32.4	10/31/25 23:45 == 47.9
10/31/25 19:20 == 32.5	10/31/25 23:50 == 47.6
10/31/25 19:25 == 32.5	10/31/25 23:55 == 47.7
10/31/25 19:30 == 32.5	
10/31/25 19:35 == 32.5	
10/31/25 19:40 == 33.6	
10/31/25 19:45 == 39.3	
10/31/25 19:50 == 47	
10/31/25 19:55 == 47.5	
10/31/25 20:00 == 48	
10/31/25 20:05 == 47.9	
10/31/25 20:10 == 47.9	
10/31/25 20:15 == 48	
10/31/25 20:20 == 47.9	
10/31/25 20:25 == 47.2	
10/31/25 20:30 == 48	
10/31/25 20:35 == 48	
10/31/25 20:40 == 47.4	
10/31/25 20:45 == 36	
10/31/25 20:50 == 32.9	
10/31/25 20:55 == 32.5	
10/31/25 21:00 == 32.5	
10/31/25 21:05 == 32.5	
10/31/25 21:10 == 32.4	
10/31/25 21:15 == 32.6	
10/31/25 21:20 == 32.5	
10/31/25 21:25 == 32.4	
10/31/25 21:30 == 32.4	
10/31/25 21:35 == 32.5	
10/31/25 21:40 == 32.5	
10/31/25 21:45 == 41	
10/31/25 21:50 == 47.6	
10/31/25 21:55 == 47.7	
10/31/25 22:00 == 47.6	
10/31/25 22:05 == 47.9	
10/31/25 22:10 == 47.8	
10/31/25 22:15 == 47.9	
10/31/25 22:20 == 48	
10/31/25 22:25 == 46	