

LORP Synopsis for November 2025

Compliance Comments

Flows were above the minimum flow for the month.

Maintenance

Activities for the month on the Lower Owens River included the following:

- Current metering continues the development of discharge curves at all in-river flow monitoring sites and are used to develop velocity indexing tables.
- Some in-river station measurements have fluctuated as a result of shifting sedimentation in the river, requiring additional indexing to increase the accuracy of measurements.

Operations

- LORPS Langemann from 8 cfs to 7 cfs on November 1, 2025.
- On November 1, 2025, flows to BWMA units for the 2025-26 Winter season were set as follows:
 - Thibaut – 2.5 cfs
 - Winterton – 4.0 cfs
 - Waggoner – 2.0 cfs
- LORP Intake from 55 cfs to 45 cfs on November 12, 2025.

Waterfowl Area Monthly Report

Synopsis (for Runoff Year 2025-2026)

Implementation of the Interim Management and Monitoring Plan continued, which includes the seasonal flooding regime and a fixed waterfowl acreage goal of 500 acres.

On March 1, 2025 (RY 2024-25) flows to all units were set to 0 cfs.

On September 15, 2025, flows for the Fall season were set as follow: Thibaut Unit – 6.5 cfs, Winterton Unit – 5.5 cfs, and Waggoner Unit – 7.5 cfs.

Wetted acreage surveys were completed for the Fall season on November 1, 2025. Thibaut measured 171 acres, Winterton measured 173 acres, and Waggoner measured 145 acres on November 3, 2024, for a combined total of 509 acres.

On November 1, 2025 flows for the 2025-26 Winter season were set. Flow to Thibaut Unit was set to 2.5 cfs. Flow to Winterton Unit was set to 4.0 cfs. Flow to Waggoner Unit was set to 2.0 cfs.

Flow Rates and Wetted Acreage Summary (for Runoff Year 2025-26)

	Inflow (cfs)	Date Set	Wetted Acreage	Date of Survey
Drew Unit	off	4/16/2021		
Waggoner Unit	off	3/1/2025		
	7.5	9/15/2025	150	11/1/2025
	2.0	11/1/2025		
Winterton Unit	Off	3/1/2025		
	5.5	9/15/2025	173	11/1/2025
	4.0	11/1/2025		
Thibaut Unit	off	3/1/2025		
	6.5	9/15/2025	171	11/1/2025
	2.5	11/1/2025		

NOVEMBER 2025 IN-RIVER STATION CURRENT METERING SUMMARY

Station	Date	Metered Flow	Station Begin Flow	Station End Flow	Shift Applied	Notes	
LORP Intake	12/2/2025	45.46	45.90	45.80	0	gage height	3.45
At Mazourka Canyon Road	12/2/2025	48.63	53.70	50.10	-3	gage height	3.37
At Reinhackle Springs	12/2/2025	54.80	52.30	54.00	2	gage height	3.65

Month: November
Year: 2025

Date	Intake			Blackrock Ditch Return		Billy Lake Return		Mazourka Canyon Road			Locust Ditch Return		Georges Ditch Return		Reinhackle Springs			Alabama Gates Release		Above Pumpstation			Pumpback Discharge		Lange-mann Release to Delta	Weir to Delta	River Daily Avg
	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Flow	Avg Month to Date		
11/01/25	55	56	15	1	1	1	1	56	55	15	0	0	0	0	56	57	15	0	0	47	54	15	40	40	7	0	54
11/02/25	55	55	15	1	1	1	1	56	54	15	0	0	0	0	57	57	15	0	0	47	53	15	40	40	7	0	54
11/03/25	55	55	15	1	1	1	1	55	54	15	0	0	0	0	57	56	15	0	0	47	52	15	40	40	7	0	54
11/04/25	55	55	15	1	1	1	1	56	54	15	0	0	0	0	57	56	15	0	0	49	52	15	42	41	7	0	54
11/05/25	56	55	15	1	1	1	1	59	54	15	0	0	0	0	56	55	15	0	0	48	51	15	41	41	7	0	55
11/06/25	56	55	15	1	1	1	1	61	55	15	0	0	0	0	58	56	15	0	0	49	50	15	42	41	7	0	56
11/07/25	56	55	15	1	1	1	1	62	55	15	0	0	0	0	59	56	15	0	0	49	50	15	42	41	7	0	57
11/08/25	55	55	15	1	1	1	1	62	56	15	0	0	0	0	62	56	15	0	0	49	49	15	42	41	7	0	57
11/09/25	55	55	15	1	1	1	1	60	57	15	0	0	0	0	60	57	15	0	0	50	49	15	43	41	7	0	56
11/10/25	56	55	15	1	1	1	1	60	57	15	0	0	0	0	60	57	15	0	0	51	49	15	44	42	7	0	57
11/11/25	56	55	15	1	1	1	1	60	58	15	0	0	0	0	60	58	15	0	0	52	49	15	45	42	7	0	57
11/12/25	50	55	15	1	1	1	1	62	58	15	0	0	0	0	62	58	15	0	0	54	49	15	47	42	7	0	57
11/13/25	46	54	15	1	1	1	1	60	59	15	0	0	0	0	60	58	15	0	0	54	49	15	47	43	7	0	55
11/14/25	46	54	15	2	1	1	1	54	59	15	0	0	0	0	60	59	15	0	0	54	50	15	47	43	7	0	54
11/15/25	46	53	15	2	1	1	1	55	59	15	0	0	1	0	62	59	15	0	0	54	50	15	47	43	7	0	54
11/16/25	45	53	15	2	1	1	1	58	59	15	0	0	0	0	61	59	15	0	0	61	51	15	47	44	7	7	56
11/17/25	45	52	15	1	1	1	1	57	59	15	0	0	0	0	62	60	15	0	0	70	53	15	47	44	7	16	59
11/18/25	45	51	15	1	1	2	1	54	59	15	0	0	0	0	59	60	15	0	0	85	55	15	47	44	7	31	61
11/19/25	46	51	15	1	1	2	1	57	59	15	0	0	0	0	56	60	15	0	0	76	57	15	47	44	7	22	59
11/20/25	44	50	15	1	1	2	1	54	58	15	0	0	0	0	61	60	15	0	0	75	59	15	47	44	7	21	59
11/21/25	45	49	15	1	1	2	1	53	58	15	0	0	0	0	59	60	15	0	0	71	60	15	47	44	7	17	57
11/22/25	45	48	15	1	1	2	1	52	57	15	0	0	0	0	56	60	15	0	0	66	61	15	47	44	7	12	55
11/23/25	46	48	15	1	1	2	1	52	57	15	0	0	0	0	56	60	15	0	0	65	63	15	47	45	7	11	55
11/24/25	46	47	15	1	1	1	1	51	56	15	0	0	0	0	55	59	15	0	0	62	63	15	47	45	7	8	54
11/25/25	46	46	15	1	1	1	1	51	55	15	0	0	0	0	54	59	15	0	0	59	64	15	47	45	7	5	53
11/26/25	46	46	15	1	1	1	1	53	55	15	0	0	0	0	54	58	15	0	0	57	64	15	47	45	7	3	53
11/27/25	46	46	15	1	1	2	1	53	54	15	0	0	0	0	54	58	15	0	0	55	64	15	47	45	7	1	52
11/28/25	46	46	15	1	1	2	1	53	54	15	0	0	0	0	54	58	15	0	0	54	64	15	47	45	7	0	52
11/29/25	46	46	15	1	1	2	1	53	54	15	0	0	0	0	54	57	15	0	0	54	64	15	47	45	7	0	52
11/30/25	45	45	15	1	1	2	1	53	54	15	0	0	0	0	54	57	15	0	0	53	64	15	46	45	7	0	51
Monthly Avg	49							56							58					57							55

Lower Owens River Project Flow Report for 11/01/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			55	56	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			56	55	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			56	57	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			47	54	15
Pump Station			40	45	
Langemann Gate to Delta			7	8	
Weir to Delta			0	2	
LORP In Channel Average Flow ²			54	56	

Pump Station Month-to-Date Average Flow 40 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	2.5 cfs	11/01/2025
Winterton	237 Acres	03/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.60 ft	(Last Collected: 10/22/2025)
Lower Twin Lake Gage Read	2.43 ft	
Goose Lake Gage Read	2.60 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/02/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			55	55	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			56	54	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			57	57	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			47	53	15
Pump Station			40	44	
Langemann Gate to Delta			7	8	
Weir to Delta			0	1	
LORP In Channel Average Flow ²			54	55	

Pump Station Month-to-Date Average Flow 40 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	2.5 cfs	11/01/2025
Winterton	237 Acres	03/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.60 ft	(Last Collected: 10/22/2025)
Lower Twin Lake Gage Read	2.43 ft	
Goose Lake Gage Read	2.60 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/03/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			55	55	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			55	54	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			57	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			47	52	15
Pump Station			40	44	
Langemann Gate to Delta			7	8	
Weir to Delta			0	1	
LORP In Channel Average Flow ²			54	54	

Pump Station Month-to-Date Average Flow 40 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	2.5 cfs	11/01/2025
Winterton	237 Acres	03/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.60 ft	(Last Collected: 10/22/2025)
Lower Twin Lake Gage Read	2.43 ft	
Goose Lake Gage Read	2.60 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/04/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			55	55	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			56	54	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			57	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			49	52	15
Pump Station			42	43	
Langemann Gate to Delta			7	8	
Weir to Delta			0	1	
LORP In Channel Average Flow ²			54	54	

Pump Station Month-to-Date Average Flow 40 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	249 Acres	03/01/2025	2.5 cfs	11/01/2025
Winterton	237 Acres	03/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	185 Acres	03/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	671 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.60 ft	(Last Collected: 10/22/2025)
Lower Twin Lake Gage Read	2.43 ft	
Goose Lake Gage Read	2.60 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/05/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			56	55	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			59	54	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			56	55	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			48	51	15
Pump Station			41	43	
Langemann Gate to Delta			7	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			55	54	

Pump Station Month-to-Date Average Flow 41 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.65 ft	(Last Collected: 11/05/2025)
Lower Twin Lake Gage Read	2.34 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/06/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			56	55	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			61	55	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			58	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			49	50	15
Pump Station			42	42	
Langemann Gate to Delta			7	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	54	

Pump Station Month-to-Date Average Flow 41 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.65 ft	(Last Collected: 11/05/2025)
Lower Twin Lake Gage Read	2.34 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/07/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			56	55	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			62	55	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			59	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			49	50	15
Pump Station			42	42	
Langemann Gate to Delta			7	8	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	54	

Pump Station Month-to-Date Average Flow 41 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.65 ft	(Last Collected: 11/05/2025)
Lower Twin Lake Gage Read	2.34 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/08/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			55	55	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			62	56	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			62	56	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			49	49	15
Pump Station			42	42	
Langemann Gate to Delta			7	7	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			57	54	

Pump Station Month-to-Date Average Flow 41 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.65 ft	(Last Collected: 11/05/2025)
Lower Twin Lake Gage Read	2.34 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/09/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			55	55	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			60	57	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			60	57	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			50	49	15
Pump Station			43	41	
Langemann Gate to Delta			7	7	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	54	

Pump Station Month-to-Date Average Flow 41 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.65 ft	(Last Collected: 11/05/2025)
Lower Twin Lake Gage Read	2.34 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/10/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			56	55	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			60	57	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			60	57	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			51	49	15
Pump Station			44	41	
Langemann Gate to Delta			7	7	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			57	55	

Pump Station Month-to-Date Average Flow 42 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.65 ft	(Last Collected: 11/05/2025)
Lower Twin Lake Gage Read	2.34 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/11/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			56	55	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			60	58	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			60	58	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			52	49	15
Pump Station			45	41	
Langemann Gate to Delta			7	7	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			57	55	

Pump Station Month-to-Date Average Flow 42 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.65 ft	(Last Collected: 11/05/2025)
Lower Twin Lake Gage Read	2.34 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/12/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			50	55	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			62	58	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			62	58	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			54	49	15
Pump Station			47	42	
Langemann Gate to Delta			7	7	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			57	55	

Pump Station Month-to-Date Average Flow 42 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.65 ft	(Last Collected: 11/05/2025)
Lower Twin Lake Gage Read	2.34 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/13/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			46	54	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			60	59	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			60	58	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			54	49	15
Pump Station			47	42	
Langemann Gate to Delta			7	7	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			55	55	

Pump Station Month-to-Date Average Flow 43 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.65 ft	(Last Collected: 11/05/2025)
Lower Twin Lake Gage Read	2.34 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/14/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			46	54	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			54	59	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			60	59	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			54	50	15
Pump Station			47	43	
Langemann Gate to Delta			7	7	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			54	55	

Pump Station Month-to-Date Average Flow 43 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.65 ft	(Last Collected: 11/05/2025)
Lower Twin Lake Gage Read	2.34 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/15/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			46	53	15
Blackrock Ditch Return (augmentation)	2	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.4	1			
Mazourka Canyon Road			55	59	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	1	0			
Reinhackle Springs			62	59	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			54	50	15
Pump Station			47	43	
Langemann Gate to Delta			7	7	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			54	55	

Pump Station Month-to-Date Average Flow 43 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.65 ft	(Last Collected: 11/05/2025)
Lower Twin Lake Gage Read	2.34 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/16/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			45	53	15
Blackrock Ditch Return (augmentation)	2	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	1			
Mazourka Canyon Road			58	59	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			61	59	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			61	51	15
Pump Station			47	44	
Langemann Gate to Delta			7	7	
Weir to Delta			7	0	
LORP In Channel Average Flow ²			56	55	

Pump Station Month-to-Date Average Flow 44 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.65 ft	(Last Collected: 11/05/2025)
Lower Twin Lake Gage Read	2.34 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/17/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			45	52	15
Blackrock Ditch Return (augmentation)	2	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	1			
Mazourka Canyon Road			57	59	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			62	60	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			70	53	15
Pump Station			47	44	
Langemann Gate to Delta			7	7	
Weir to Delta			16	2	
LORP In Channel Average Flow ²			58	56	

Pump Station Month-to-Date Average Flow 44 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.65 ft	(Last Collected: 11/05/2025)
Lower Twin Lake Gage Read	2.34 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/18/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			45	51	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	1			
Mazourka Canyon Road			54	59	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			59	60	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			85	55	15
Pump Station			47	45	
Langemann Gate to Delta			7	7	
Weir to Delta			31	4	
LORP In Channel Average Flow ²			61	56	

Pump Station Month-to-Date Average Flow 44 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.65 ft	(Last Collected: 11/05/2025)
Lower Twin Lake Gage Read	2.34 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/19/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			46	51	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.6	1			
Mazourka Canyon Road			57	59	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			56	60	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			76	57	15
Pump Station			47	45	
Langemann Gate to Delta			7	7	
Weir to Delta			22	5	
LORP In Channel Average Flow ²			59	57	

Pump Station Month-to-Date Average Flow 44 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.65 ft	(Last Collected: 11/05/2025)
Lower Twin Lake Gage Read	2.34 ft	
Goose Lake Gage Read	2.66 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/20/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			44	50	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.6	1			
Mazourka Canyon Road			54	58	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			61	60	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			75	59	15
Pump Station			47	45	
Langemann Gate to Delta			7	7	
Weir to Delta			21	6	
LORP In Channel Average Flow ²			58	57	

Pump Station Month-to-Date Average Flow 44 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.47 ft	(Last Collected: 11/19/2025)
Lower Twin Lake Gage Read	2.41 ft	
Goose Lake Gage Read	2.70 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/21/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			45	49	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.6	1			
Mazourka Canyon Road			53	58	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			59	60	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			71	60	15
Pump Station			47	46	
Langemann Gate to Delta			7	7	
Weir to Delta			17	8	
LORP In Channel Average Flow ²			57	57	

Pump Station Month-to-Date Average Flow 44 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.47 ft	(Last Collected: 11/19/2025)
Lower Twin Lake Gage Read	2.41 ft	
Goose Lake Gage Read	2.70 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/22/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			45	48	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	1			
Mazourka Canyon Road			52	57	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			56	60	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			66	61	15
Pump Station			47	46	
Langemann Gate to Delta			7	7	
Weir to Delta			12	8	
LORP In Channel Average Flow ²			55	57	

Pump Station Month-to-Date Average Flow 44 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.47 ft	(Last Collected: 11/19/2025)
Lower Twin Lake Gage Read	2.41 ft	
Goose Lake Gage Read	2.70 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/23/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			46	48	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	1			
Mazourka Canyon Road			52	57	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			56	60	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			65	63	15
Pump Station			47	46	
Langemann Gate to Delta			7	7	
Weir to Delta			11	9	
LORP In Channel Average Flow ²			55	57	

Pump Station Month-to-Date Average Flow 45 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.47 ft	(Last Collected: 11/19/2025)
Lower Twin Lake Gage Read	2.41 ft	
Goose Lake Gage Read	2.70 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/24/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			46	47	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	1			
Mazourka Canyon Road			51	56	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			55	59	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			62	63	15
Pump Station			47	47	
Langemann Gate to Delta			7	7	
Weir to Delta			8	10	
LORP In Channel Average Flow ²			54	56	

Pump Station Month-to-Date Average Flow 45 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.47 ft	(Last Collected: 11/19/2025)
Lower Twin Lake Gage Read	2.41 ft	
Goose Lake Gage Read	2.70 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/25/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			46	46	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	1			
Mazourka Canyon Road			51	55	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			54	59	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			59	64	15
Pump Station			47	47	
Langemann Gate to Delta			7	7	
Weir to Delta			5	10	
LORP In Channel Average Flow ²			52	56	

Pump Station Month-to-Date Average Flow 45 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.47 ft	(Last Collected: 11/19/2025)
Lower Twin Lake Gage Read	2.41 ft	
Goose Lake Gage Read	2.70 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/26/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			46	46	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	1			
Mazourka Canyon Road			53	55	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			54	58	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			57	64	15
Pump Station			47	47	
Langemann Gate to Delta			7	7	
Weir to Delta			3	10	
LORP In Channel Average Flow ²			52	56	

Pump Station Month-to-Date Average Flow 45 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.47 ft	(Last Collected: 11/19/2025)
Lower Twin Lake Gage Read	2.41 ft	
Goose Lake Gage Read	2.70 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/27/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			46	46	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	1			
Mazourka Canyon Road			53	54	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			54	58	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			55	64	15
Pump Station			47	47	
Langemann Gate to Delta			7	7	
Weir to Delta			1	10	
LORP In Channel Average Flow ²			52	56	

Pump Station Month-to-Date Average Flow 45 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.47 ft	(Last Collected: 11/19/2025)
Lower Twin Lake Gage Read	2.41 ft	
Goose Lake Gage Read	2.70 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/28/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			46	46	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	1			
Mazourka Canyon Road			53	54	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			54	58	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			54	64	15
Pump Station			47	47	
Langemann Gate to Delta			7	7	
Weir to Delta			0	10	
LORP In Channel Average Flow ²			52	55	

Pump Station Month-to-Date Average Flow 45 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.47 ft	(Last Collected: 11/19/2025)
Lower Twin Lake Gage Read	2.41 ft	
Goose Lake Gage Read	2.70 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/29/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			46	46	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.6	2			
Mazourka Canyon Road			53	54	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			54	57	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			54	64	15
Pump Station			47	47	
Langemann Gate to Delta			7	7	
Weir to Delta			0	10	
LORP In Channel Average Flow ²			52	55	

Pump Station Month-to-Date Average Flow 45 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.47 ft	(Last Collected: 11/19/2025)
Lower Twin Lake Gage Read	2.41 ft	
Goose Lake Gage Read	2.70 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 11/30/2025

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			45	45	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	0	0			
Billy Lake Return (augmentation)	1.5	2			
Mazourka Canyon Road			53	54	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	0	0			
Reinhackle Springs			54	57	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			53	64	15
Pump Station			46	47	
Langemann Gate to Delta			7	7	
Weir to Delta			0	10	
LORP In Channel Average Flow ²			51	55	

Pump Station Month-to-Date Average Flow 45 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut	171 Acres	11/01/2025	2.5 cfs	11/01/2025
Winterton	173 Acres	11/01/2025	4.0 cfs	11/01/2025
Drew	0 Acres	09/14/2021	0 cfs	04/16/2021
Waggoner	150 Acres	11/01/2025	2.0 cfs	11/01/2025
Total Flooded Area	494 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.47 ft	(Last Collected: 11/19/2025)
Lower Twin Lake Gage Read	2.41 ft	
Goose Lake Gage Read	2.70 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 11/01/2025)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Courtnie Cappello

DATE: October 31, 2025

REQUESTED BY: Tony Tillemans x32259

START DATE: Saturday, 11/1/2025

TIME: morning

Winter 2025-26 – BWMA Flows	
Location	Set flows to (cfs)
Thibaut Spillgate East Weir (MS 0105)	2.5
Winterton Div #2 (MS 0194)	4.0
Waggoner Div #8 (MS 0200)	2.0

C: Adam Perez
Eric Tillemans
Ben Butler
Jason Olin
Lori Dermody
Bruce Peterson
Chad Lamacchia

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Courtnie Cappello

DATE: November 12, 2025

REQUESTED BY: Tony Tillemans x32259

FLOW CHANGE LOCATION **LORP Intake**

START DATE: Wednesday, November 12, 2025 TIME: morning

CHANGE FLOW: From: 55 cfs To: 45 cfs

To maintain required flows to the LORP, monitor and make adjustments to the Aqueduct Intake gates for at least one day following this flow change.

C:	Adam Perez	Ben Butler
	Eric Tillemans	Jason Olin
	Forest Mathieu	Bruce Peterson
	Ryan Yeager	Gary Reiser
	Joe Bowling	Chad Lamacchia

Quality Assurance and Calibration Procedures

The Los Angeles Department of Water and Power has a set standard to assure quality of all hydrological data collected. Procedures used to QA data vary based on the type of data collected and the device used to measure flow.

Data collected from sites utilizing area velocity flow meters are electronically monitored continuously. Sites are physically visited most days of the week to assure debris or vandalism hasn't affected the reading. Errors in the data collected may arise from several sources:

1. The transducers which detect the stage height and velocities have a tendency to drift.
2. Power outages occur occasionally thereby preventing the recording of data to the data loggers.
3. Occasionally the data loggers themselves malfunction.
4. Data can be lost or corrupted when it is transferred from the data loggers to the laptop.

Errors in discharge can originate from the instability of the relationship between velocity and stage height. This relationship varies temporally. It is affected by changes in the streambed that results from the flow of water over the bed, such as scour and fill, aquatic growth, ice, debris, or bed roughness.

To compensate for changes in the constantly shifting conditions multiple current meter measurements at each location per USGS standards are conducted per month. The current meter shots are taken at 2 foot intervals horizontally across the lined sections or 1 foot intervals at the sites where the measurements are taken in culverts. In each vertical section two separate measurements are taken (0.2 and 0.8) of the depth to achieve the best velocity average in the vertical. These vertical discharges are then added together to obtain a total flow in the section. The current meter data is logged in an on-board computer tracking the measurements as taken. That data is then extracted from the on-board computer to a PC using the FlowPack software that allows analysis of the data for erroneous measurements and is then converted to an Excel spreadsheet for ease of storage and printing. See Examples 1 – 3 for printout of software used to validate the current meter data.

Current meter data is used to develop velocity index tables. The tables require a minimum of 6 meter shots. After a table has been developed it is then downloaded into the on-site SonTek software which takes into account any variables within the meter section and applies any shifts to the discharge.

Data is collected and logged every 10 minutes utilizing SonTek area velocity flow meters. The data is downloaded from the meters once per month utilizing software provided by SonTek. The software "ViewArgonaut" gives us the ability to check items relevant to the performance of the meter. Battery voltage, beam strength, noise ratios, depth, and cell distance. (See Example 4) The software provides a trend of the data collected and displays it for quick comparisons, flagging discrepancies, one day at a time. Utilizing the ViewArgonaut software monthly reports are generated and the data is

reviewed. Using the current meter data collected during the month shifts are applied to the discharge to assure accuracy.

Augmentation Flows

Flows at several of the augmentation points are measured using weirs and flumes at sites that were pre-existing. Billy Lake has a one foot Parshall flume, Locust and Georges Returns have three foot weirs installed. All have stilling wells with dataloggers installed. The water surface elevation in the stillwell is measured each time the site is visited and verified it matches the staff gage for correct water depth through the measuring device. The still wells are flushed once every two months to assure the communication line is open and free of debris. The gage height data is logged on a module every 15 minutes. The modules are changed and processed every two weeks. Software used to process the data gives an hourly average gage and converts it to flow. It also gives the maximum and minimum flows for each day and time stamps it. The data is reviewed for any discrepancies which can be caused as a result of debris plugging the measuring device, a plugged stillwell, low batteries, etc.

SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:

[Open a FlowTracker file](#)[Open many FlowTracker files/folders](#)

The current export settings are:

- ☒ Show Discharge Summary Report
- ☒ Export ASCII Discharge file (DIS)
- ☒ Export ASCII Control file (CTL)
- ☒ Export ASCII Summary file (SUM)
- ☒ Export ASCII Data file (DAT)
- ☒ Export FlowPack file (FPX)
- ☒ Put Headers on ASCII files

[Connect to a FlowTracker](#)

To download data and run diagnostics

[Program Settings](#)[Quality Control Settings](#)[Show User's Manual](#)[Show Technical Manual](#)[Show Quick Start](#)[About FlowTracker](#)

English



A YSI Environmental Company

070706.0RABR.LOR.WAD

Discharge Measurement Summary

Date Generated: Thu Sep 27 2007

File Information

File Name 070706.0RABR.LOR.WAD
Start Date and Time 2007/07/06 07:48:17

Site Details

Site Name ORABR
Operator(s) DJT

System Information

Sensor Type FlowTracker
Serial # P1685
CPU Firmware Version 3.2
Software Ver 2.11

Units

(English Units)

Distance ft
Velocity ft/s
Area ft²
Discharge cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.1%	0.5%
Velocity	0.3%	1.4%
Width	0.1%	0.1%
Method	0.8%	-
# Stations	1.6%	-
Overall	2.1%	1.8%

Summary

Averaging Int.	40	# Stations	32
Start Edge	REW	Total Width	48.100
Mean SNR	18.7 dB	Total Area	69.016
Mean Temp	73.68 °F	Mean Depth	1.435
Disch. Equation	Mid-Section	Mean Velocity	0.6419
		Total Discharge	44.3025

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	07:48	23.60	None	0.000	0.0	0.0	0.0000	1.00	0.0000	0.000	0.0000	0.0
1	07:48	24.60	0.6	0.360	0.6	0.144	0.2762	1.00	0.2762	0.360	0.0994	0.2
2	07:50	25.60	0.6	0.640	0.6	0.256	0.5102	1.00	0.5102	0.640	0.3266	0.7
3	07:51	26.60	0.6	0.880	0.6	0.352	0.5938	1.00	0.5938	0.880	0.5225	1.2
4	07:52	27.60	0.6	1.180	0.6	0.472	0.6257	1.00	0.6257	1.180	0.7383	1.7
5	07:54	28.60	0.6	1.390	0.6	0.556	0.6302	1.00	0.6302	1.390	0.8761	2.0
6	07:55	29.60	0.2/0.8	1.520	0.2	1.216	0.8130	1.00	0.7078	1.520	1.0759	2.4
6	07:56	29.60	0.2/0.8	1.520	0.8	0.304	0.6027					
7	07:58	30.60	0.8/0.2	1.690	0.2	1.352	0.8468	1.00	0.7664	1.690	1.2952	2.9
7	07:57	30.60	0.8/0.2	1.690	0.8	0.338	0.6860					
8	07:59	31.60	0.2/0.8	1.700	0.2	1.360	0.8146	1.00	0.7037	2.040	1.4357	3.2
8	08:00	31.60	0.2/0.8	1.700	0.8	0.340	0.5928					
9	08:03	33.00	0.8/0.2	1.680	0.2	1.344	0.8383	1.00	0.7408	2.016	1.4935	3.4
9	08:01	33.00	0.8/0.2	1.680	0.8	0.336	0.6434					
10	08:05	34.00	0.2/0.8	1.600	0.2	1.280	0.8724	1.00	0.7398	2.400	1.7757	4.0
10	08:06	34.00	0.2/0.8	1.600	0.8	0.320	0.6073					
11	08:08	36.00	0.8/0.2	1.520	0.2	1.216	0.8186	1.00	0.6995	3.040	2.1264	4.8
11	08:07	36.00	0.8/0.2	1.520	0.8	0.304	0.5804					
12	08:09	38.00	0.2/0.8	1.500	0.2	1.200	0.8957	1.00	0.7461	3.000	2.2382	5.1
12	08:11	38.00	0.2/0.8	1.500	0.8	0.300	0.5965					
13	08:12	40.00	0.2/0.8	1.490	0.2	1.192	0.8245	1.00	0.6321	2.980	1.8837	4.3
13	08:13	40.00	0.2/0.8	1.490	0.8	0.298	0.4396					
14	08:15	42.00	0.2/0.8	1.510	0.2	1.208	0.8514	1.00	0.7548	3.020	2.2791	5.1
14	08:16	42.00	0.2/0.8	1.510	0.8	0.302	0.6581					
15	08:18	44.00	0.8/0.2	1.600	0.2	1.280	0.8278	1.00	0.7026	3.200	2.2484	5.1
15	08:17	44.00	0.8/0.2	1.600	0.8	0.320	0.5774					
16	08:19	46.00	0.2/0.8	1.620	0.2	1.296	0.8018	1.00	0.6916	3.240	2.2409	5.1
16	08:20	46.00	0.2/0.8	1.620	0.8	0.324	0.5814					
17	08:22	48.00	0.8/0.2	1.700	0.2	1.360	0.8396	1.00	0.7756	3.400	2.6372	6.0
17	08:21	48.00	0.8/0.2	1.700	0.8	0.340	0.7116					
18	08:23	50.00	0.2/0.8	1.800	0.2	1.440	0.9016	1.00	0.8251	3.600	2.9703	6.7
18	08:24	50.00	0.2/0.8	1.800	0.8	0.360	0.7487					
19	08:26	52.00	0.8/0.2	1.680	0.2	1.344	0.8271	1.00	0.7269	3.360	2.4425	5.5
19	08:25	52.00	0.8/0.2	1.680	0.8	0.336	0.6266					
20	08:27	54.00	0.2/0.8	1.780	0.2	1.424	0.7795	1.00	0.6763	3.560	2.4076	5.4
20	08:28	54.00	0.2/0.8	1.780	0.8	0.356	0.5732					
21	08:30	56.00	0.8/0.2	1.820	0.2	1.456	0.7329	1.00	0.6097	3.640	2.2193	5.0
21	08:29	56.00	0.8/0.2	1.820	0.8	0.364	0.4865					
22	08:32	58.00	0.2/0.8	1.820	0.2	1.456	0.7123	1.00	0.5540	3.640	2.0163	4.6
22	08:34	58.00	0.2/0.8	1.820	0.8	0.364	0.3957					
23	08:36	60.00	0.8/0.2	1.800	0.2	1.440	0.6949	1.00	0.6017	3.600	2.1660	4.9
23	08:35	60.00	0.8/0.2	1.800	0.8	0.360	0.5085					

SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:

[Open a FlowTracker file](#)[Open many FlowTracker files/folders](#)**The current export settings are:**

- ☒ Show Discharge Summary Report
- ☒ Export ASCII Discharge file (DIS)
- ☒ Export ASCII Control file (CTL)
- ☒ Export ASCII Summary file (SUM)
- ☒ Export ASCII Data file (DAT)
- ☒ Export FlowPack file (FPX)
- ☒ Put Headers on ASCII files

[Connect to a FlowTracker](#)

To download data and run diagnostics




[Program Settings](#)[Quality Control Settings](#)[Show User's Manual](#)[Show Technical Manual](#)[Show Quick Start](#)[About FlowTracker](#)

English



A YSI Environmental Company

070706.0RABR.LOR.WAD




Quality Control

St	Loc	%Dep	Message
13	40.00	0.8	High standard error: 0.024

Automatic Quality Control Test (BeamCheck)

Fri Jul 6 07:47:10 PDT 2007



SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:

[Open a FlowTracker file](#)[Open many FlowTracker files/folders](#)**The current export settings are:**

- ☒ Show Discharge Summary Report
- ☒ Export ASCII Discharge file (DIS)
- ☒ Export ASCII Control file (CTL)
- ☒ Export ASCII Summary file (SUM)
- ☒ Export ASCII Data file (DAT)
- ☒ Export FlowPack file (FPX)
- ☒ Put Headers on ASCII files

[Connect to a FlowTracker](#)

To download data and run diagnostics




[Program Settings](#)[Quality Control Settings](#)[Show User's Manual](#)[Show Technical Manual](#)[Show Quick Start](#)[About FlowTracker](#)

English



A YSI Environmental Company


070706.0RABR.LOR.WAD




Quality Control

St	Loc	%Dep	Message
13	40.00	0.8	High standard error: 0.024

Automatic Quality Control Test (BeamCheck)



FileName: BROR_070801_a.arg (Argonaut- SW 3000 kHz)



05:58:38 22:38:38 15:18:38 07:58:38 00:38:38 17:18:38
03/07/2007 03/07/2007 04/07/2007 05/07/2007 06/07/2007 06/07/2007

System	Argonaut-SW
Frequency	3000 kHz
File	BROR_070801_a
File Size	65.18 kB
Sample No	1
Sample Date	02/07/2007
Sample Time	13:28:38
Time Interval	180

Velocity Data:	
V1/X/E(cm/s)	27.8
V2/Y/N(cm/s)	2.4
V3/Z/U(cm/s)	--
Speed (cm/s)	27.9
Direction(deg)	85.1

Discharge Summary:	
V Beam (m)	0.426
Stage (m)	1.304
VMean (cm/s)	22.7
Flow (cfs)	50.21
Area (m2)	6.26
Vol (acre-ft)	0.7

Diagnostic Data:	
SNR1 (dB)	61
SNR2 (dB)	61
SNR3 (dB)	--
StErr1 (cm/s)	0.9
StErr2 (cm/s)	0.8
StErr3 (cm/s)	--
Mean StDev	0.9
Battery (V)	12.4

Party: BLP / BJA	Width: 29.7 ft	Processed by: BJA
Boat/Motor: BOAT	Area: 126 ft²	Mean Velocity: 0.361 ft/s
Gage Height: 5.38 ft	G.H.Change: 0.000 ft	Discharge: 45.5 ft³/s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.00°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft²	Diff.: 0.000%
Depth: Composite (BT)	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:		ADCP:
BT 3-Beam Solution: YES	Max. Vel.: 1.16 ft/s	Type/Freq.: StreamPro / 2000 kHz
WT 3-Beam Solution: YES	Max. Depth: 5.52 ft	Serial #: 2370 Firmware: 31.17
BT Error Vel.: 0.33 ft/s	Mean Depth: 4.25 ft	Bin Size: 17 cm Blank: 3 cm
WT Error Vel.: 0.98 ft/s	% Meas.: 62.05	BT Mode: 10 BT Pings: 2
BT Up Vel.: 1.00 ft/s	Water Temp.: None	WT Mode: 12 WT Pings: 6
WT Up Vel.: 1.64 ft/s	ADCP Temp.: 63.4 °F	
Use Weighted Mean Depth: YES		

Performed Diag. Test: YES
 Performed Moving Bed Test: NO
 Performed Compass Calibration: NO Evaluation: NO
 Meas. Location: BRIDGE

Project Name: 251202 LOR @ INTAKE_0.mmt
 Software: 2.26.00.04

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	L	2	2	54	7.27	28.3	8.51	0.212	1.66	45.9	30	128	13:14	13:15	0.49	0.36	7	0
001	R	2	2	51	7.20	28.0	7.95	0.283	1.73	45.2	32	136	13:15	13:16	0.51	0.33	18	0
004	L	2	2	43	7.66	28.9	8.37	0.388	1.62	47.0	29	120	13:18	13:19	0.55	0.39	0	0
005	R	2	2	39	7.06	27.6	7.24	0.459	1.38	43.8	29	121	13:20	13:20	0.59	0.36	0	0
Mean		2	2	46	7.30	28.2	8.02	0.335	1.60	45.5	30	126	Total	00:06	0.54	0.36	6	0
SDev		0	0	7	0.257	0.545	0.571	0.110	0.154	1.36	1.3	7.2			0.04	0.02		
SD/M		0.0%	0.0%	15.2%	3.5%	1.9%	7.1%	32.7%	9.6%	3.0%	4.5%	5.7%			8.1%	6.3%		

Remarks:

Blackrock Return Ditch

Station 0208

Date	Flow (cfs)
11/1/2025	1.33
11/2/2025	1.30
11/3/2025	1.14
11/4/2025	1.18
11/5/2025	1.23
11/6/2025	1.20
11/7/2025	1.23
11/8/2025	1.19
11/9/2025	1.12
11/10/2025	1.08
11/11/2025	1.22
11/12/2025	1.21
11/13/2025	0.94
11/14/2025	2.37
11/15/2025	1.67
11/16/2025	1.88
11/17/2025	1.48
11/18/2025	1.34
11/19/2025	1.29
11/20/2025	1.23
11/21/2025	1.19
11/22/2025	1.20
11/23/2025	1.23
11/24/2025	1.23
11/25/2025	1.21
11/26/2025	1.17
11/27/2025	1.17
11/28/2025	1.20
11/29/2025	1.25
11/30/2025	1.28

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/1/2025	12:00:00 AM	0.53
11/1/2025	12:15:00 AM	0.53
11/1/2025	12:30:00 AM	0.53
11/1/2025	12:45:00 AM	0.53
11/1/2025	1:00:00 AM	0.53
11/1/2025	1:15:00 AM	0.53
11/1/2025	1:30:00 AM	0.53
11/1/2025	1:45:00 AM	0.53
11/1/2025	2:00:00 AM	0.53
11/1/2025	2:15:00 AM	0.53
11/1/2025	2:30:00 AM	0.53
11/1/2025	2:45:00 AM	0.53
11/1/2025	3:00:00 AM	0.53
11/1/2025	3:15:00 AM	0.53
11/1/2025	3:30:00 AM	0.53
11/1/2025	3:45:00 AM	0.53
11/1/2025	4:00:00 AM	0.53
11/1/2025	4:15:00 AM	0.53
11/1/2025	4:30:00 AM	0.53
11/1/2025	4:45:00 AM	0.53
11/1/2025	5:00:00 AM	0.53
11/1/2025	5:15:00 AM	0.53
11/1/2025	5:30:00 AM	0.53
11/1/2025	5:45:00 AM	0.53
11/1/2025	6:00:00 AM	0.53
11/1/2025	6:15:00 AM	0.53
11/1/2025	6:30:00 AM	0.53
11/1/2025	6:45:00 AM	0.53
11/1/2025	7:00:00 AM	0.53
11/1/2025	7:15:00 AM	0.53
11/1/2025	7:30:00 AM	0.53
11/1/2025	7:45:00 AM	0.53
11/1/2025	8:00:00 AM	0.53
11/1/2025	8:15:00 AM	0.53
11/1/2025	8:30:00 AM	0.53
11/1/2025	8:45:00 AM	0.53
11/1/2025	9:00:00 AM	0.53
11/1/2025	9:15:00 AM	0.53
11/1/2025	9:30:00 AM	0.53
11/1/2025	9:45:00 AM	0.53
11/1/2025	10:00:00 AM	0.53
11/1/2025	10:15:00 AM	0.53
11/1/2025	10:30:00 AM	0.53
11/1/2025	10:45:00 AM	0.53
11/1/2025	11:00:00 AM	0.53
11/1/2025	11:15:00 AM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/1/2025	11:30:00 AM	0.53
11/1/2025	11:45:00 AM	0.53
11/1/2025	12:00:00 PM	0.53
11/1/2025	12:15:00 PM	0.53
11/1/2025	12:30:00 PM	0.53
11/1/2025	12:45:00 PM	0.53
11/1/2025	1:00:00 PM	0.54
11/1/2025	1:15:00 PM	0.54
11/1/2025	1:30:00 PM	0.54
11/1/2025	1:45:00 PM	0.54
11/1/2025	2:00:00 PM	0.54
11/1/2025	2:15:00 PM	0.54
11/1/2025	2:30:00 PM	0.54
11/1/2025	2:45:00 PM	0.54
11/1/2025	3:00:00 PM	0.54
11/1/2025	3:15:00 PM	0.54
11/1/2025	3:30:00 PM	0.54
11/1/2025	3:45:00 PM	0.54
11/1/2025	4:00:00 PM	0.54
11/1/2025	4:15:00 PM	0.54
11/1/2025	4:30:00 PM	0.54
11/1/2025	4:45:00 PM	0.54
11/1/2025	5:00:00 PM	0.54
11/1/2025	5:15:00 PM	0.54
11/1/2025	5:30:00 PM	0.54
11/1/2025	5:45:00 PM	0.54
11/1/2025	6:00:00 PM	0.54
11/1/2025	6:15:00 PM	0.54
11/1/2025	6:30:00 PM	0.55
11/1/2025	6:45:00 PM	0.54
11/1/2025	7:00:00 PM	0.55
11/1/2025	7:15:00 PM	0.55
11/1/2025	7:30:00 PM	0.55
11/1/2025	7:45:00 PM	0.55
11/1/2025	8:00:00 PM	0.55
11/1/2025	8:15:00 PM	0.55
11/1/2025	8:30:00 PM	0.55
11/1/2025	8:45:00 PM	0.55
11/1/2025	9:00:00 PM	0.55
11/1/2025	9:15:00 PM	0.55
11/1/2025	9:30:00 PM	0.56
11/1/2025	9:45:00 PM	0.56
11/1/2025	10:00:00 PM	0.56
11/1/2025	10:15:00 PM	0.56
11/1/2025	10:30:00 PM	0.56
11/1/2025	10:45:00 PM	0.55

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/1/2025	11:00:00 PM	0.55
11/1/2025	11:15:00 PM	0.55
11/1/2025	11:30:00 PM	0.55
11/1/2025	11:45:00 PM	0.55
11/2/2025	12:00:00 AM	0.55
11/2/2025	12:15:00 AM	0.55
11/2/2025	12:30:00 AM	0.55
11/2/2025	12:45:00 AM	0.55
11/2/2025	1:00:00 AM	0.55
11/2/2025	1:15:00 AM	0.55
11/2/2025	1:30:00 AM	0.55
11/2/2025	1:45:00 AM	0.55
11/2/2025	2:00:00 AM	0.55
11/2/2025	2:15:00 AM	0.55
11/2/2025	2:30:00 AM	0.55
11/2/2025	2:45:00 AM	0.55
11/2/2025	3:00:00 AM	0.55
11/2/2025	3:15:00 AM	0.55
11/2/2025	3:30:00 AM	0.55
11/2/2025	3:45:00 AM	0.55
11/2/2025	4:00:00 AM	0.55
11/2/2025	4:15:00 AM	0.55
11/2/2025	4:30:00 AM	0.55
11/2/2025	4:45:00 AM	0.55
11/2/2025	5:00:00 AM	0.55
11/2/2025	5:15:00 AM	0.54
11/2/2025	5:30:00 AM	0.54
11/2/2025	5:45:00 AM	0.54
11/2/2025	6:00:00 AM	0.54
11/2/2025	6:15:00 AM	0.54
11/2/2025	6:30:00 AM	0.54
11/2/2025	6:45:00 AM	0.54
11/2/2025	7:00:00 AM	0.54
11/2/2025	7:15:00 AM	0.54
11/2/2025	7:30:00 AM	0.54
11/2/2025	7:45:00 AM	0.54
11/2/2025	8:00:00 AM	0.54
11/2/2025	8:15:00 AM	0.54
11/2/2025	8:30:00 AM	0.54
11/2/2025	8:45:00 AM	0.54
11/2/2025	9:00:00 AM	0.54
11/2/2025	9:15:00 AM	0.54
11/2/2025	9:30:00 AM	0.54
11/2/2025	9:45:00 AM	0.54
11/2/2025	10:00:00 AM	0.53
11/2/2025	10:15:00 AM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/2/2025	10:30:00 AM	0.53
11/2/2025	10:45:00 AM	0.53
11/2/2025	11:00:00 AM	0.53
11/2/2025	11:15:00 AM	0.53
11/2/2025	11:30:00 AM	0.53
11/2/2025	11:45:00 AM	0.53
11/2/2025	12:00:00 PM	0.53
11/2/2025	12:15:00 PM	0.53
11/2/2025	12:30:00 PM	0.53
11/2/2025	12:45:00 PM	0.53
11/2/2025	1:00:00 PM	0.53
11/2/2025	1:15:00 PM	0.53
11/2/2025	1:30:00 PM	0.53
11/2/2025	1:45:00 PM	0.53
11/2/2025	2:00:00 PM	0.53
11/2/2025	2:15:00 PM	0.53
11/2/2025	2:30:00 PM	0.53
11/2/2025	2:45:00 PM	0.52
11/2/2025	3:00:00 PM	0.52
11/2/2025	3:15:00 PM	0.52
11/2/2025	3:30:00 PM	0.52
11/2/2025	3:45:00 PM	0.52
11/2/2025	4:00:00 PM	0.52
11/2/2025	4:15:00 PM	0.52
11/2/2025	4:30:00 PM	0.52
11/2/2025	4:45:00 PM	0.52
11/2/2025	5:00:00 PM	0.52
11/2/2025	5:15:00 PM	0.52
11/2/2025	5:30:00 PM	0.52
11/2/2025	5:45:00 PM	0.52
11/2/2025	6:00:00 PM	0.52
11/2/2025	6:15:00 PM	0.52
11/2/2025	6:30:00 PM	0.52
11/2/2025	6:45:00 PM	0.52
11/2/2025	7:00:00 PM	0.51
11/2/2025	7:15:00 PM	0.51
11/2/2025	7:30:00 PM	0.51
11/2/2025	7:45:00 PM	0.51
11/2/2025	8:00:00 PM	0.51
11/2/2025	8:15:00 PM	0.51
11/2/2025	8:30:00 PM	0.51
11/2/2025	8:45:00 PM	0.51
11/2/2025	9:00:00 PM	0.51
11/2/2025	9:15:00 PM	0.51
11/2/2025	9:30:00 PM	0.51
11/2/2025	9:45:00 PM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/2/2025	10:00:00 PM	0.51
11/2/2025	10:15:00 PM	0.51
11/2/2025	10:30:00 PM	0.51
11/2/2025	10:45:00 PM	0.51
11/2/2025	11:00:00 PM	0.5
11/2/2025	11:15:00 PM	0.51
11/2/2025	11:30:00 PM	0.5
11/2/2025	11:45:00 PM	0.5
11/3/2025	12:00:00 AM	0.5
11/3/2025	12:15:00 AM	0.5
11/3/2025	12:30:00 AM	0.5
11/3/2025	12:45:00 AM	0.5
11/3/2025	1:00:00 AM	0.5
11/3/2025	1:15:00 AM	0.5
11/3/2025	1:30:00 AM	0.5
11/3/2025	1:45:00 AM	0.5
11/3/2025	2:00:00 AM	0.5
11/3/2025	2:15:00 AM	0.5
11/3/2025	2:30:00 AM	0.5
11/3/2025	2:45:00 AM	0.5
11/3/2025	3:00:00 AM	0.5
11/3/2025	3:15:00 AM	0.5
11/3/2025	3:30:00 AM	0.5
11/3/2025	3:45:00 AM	0.5
11/3/2025	4:00:00 AM	0.5
11/3/2025	4:15:00 AM	0.49
11/3/2025	4:30:00 AM	0.49
11/3/2025	4:45:00 AM	0.49
11/3/2025	5:00:00 AM	0.49
11/3/2025	5:15:00 AM	0.49
11/3/2025	5:30:00 AM	0.49
11/3/2025	5:45:00 AM	0.49
11/3/2025	6:00:00 AM	0.49
11/3/2025	6:15:00 AM	0.49
11/3/2025	6:30:00 AM	0.49
11/3/2025	6:45:00 AM	0.49
11/3/2025	7:00:00 AM	0.49
11/3/2025	7:15:00 AM	0.49
11/3/2025	7:30:00 AM	0.49
11/3/2025	7:45:00 AM	0.49
11/3/2025	8:00:00 AM	0.49
11/3/2025	8:15:00 AM	0.49
11/3/2025	8:30:00 AM	0.49
11/3/2025	8:45:00 AM	0.49
11/3/2025	9:00:00 AM	0.49
11/3/2025	9:15:00 AM	0.49

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/3/2025	9:30:00 AM	0.49
11/3/2025	9:45:00 AM	0.49
11/3/2025	10:00:00 AM	0.48
11/3/2025	10:15:00 AM	0.48
11/3/2025	10:30:00 AM	0.48
11/3/2025	10:45:00 AM	0.48
11/3/2025	11:00:00 AM	0.48
11/3/2025	11:15:00 AM	0.48
11/3/2025	11:30:00 AM	0.48
11/3/2025	11:45:00 AM	0.48
11/3/2025	12:00:00 PM	0.48
11/3/2025	12:15:00 PM	0.48
11/3/2025	12:30:00 PM	0.48
11/3/2025	12:45:00 PM	0.48
11/3/2025	1:00:00 PM	0.48
11/3/2025	1:15:00 PM	0.48
11/3/2025	1:30:00 PM	0.48
11/3/2025	1:45:00 PM	0.48
11/3/2025	2:00:00 PM	0.48
11/3/2025	2:15:00 PM	0.48
11/3/2025	2:30:00 PM	0.48
11/3/2025	2:45:00 PM	0.48
11/3/2025	3:00:00 PM	0.48
11/3/2025	3:15:00 PM	0.48
11/3/2025	3:30:00 PM	0.48
11/3/2025	3:45:00 PM	0.48
11/3/2025	4:00:00 PM	0.48
11/3/2025	4:15:00 PM	0.48
11/3/2025	4:30:00 PM	0.48
11/3/2025	4:45:00 PM	0.48
11/3/2025	5:00:00 PM	0.48
11/3/2025	5:15:00 PM	0.48
11/3/2025	5:30:00 PM	0.48
11/3/2025	5:45:00 PM	0.48
11/3/2025	6:00:00 PM	0.48
11/3/2025	6:15:00 PM	0.48
11/3/2025	6:30:00 PM	0.48
11/3/2025	6:45:00 PM	0.48
11/3/2025	7:00:00 PM	0.48
11/3/2025	7:15:00 PM	0.48
11/3/2025	7:30:00 PM	0.48
11/3/2025	7:45:00 PM	0.48
11/3/2025	8:00:00 PM	0.48
11/3/2025	8:15:00 PM	0.48
11/3/2025	8:30:00 PM	0.48
11/3/2025	8:45:00 PM	0.48

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/3/2025	9:00:00 PM	0.48
11/3/2025	9:15:00 PM	0.48
11/3/2025	9:30:00 PM	0.48
11/3/2025	9:45:00 PM	0.48
11/3/2025	10:00:00 PM	0.48
11/3/2025	10:15:00 PM	0.48
11/3/2025	10:30:00 PM	0.48
11/3/2025	10:45:00 PM	0.48
11/3/2025	11:00:00 PM	0.48
11/3/2025	11:15:00 PM	0.48
11/3/2025	11:30:00 PM	0.48
11/3/2025	11:45:00 PM	0.48
11/4/2025	12:00:00 AM	0.48
11/4/2025	12:15:00 AM	0.48
11/4/2025	12:30:00 AM	0.48
11/4/2025	12:45:00 AM	0.48
11/4/2025	1:00:00 AM	0.48
11/4/2025	1:15:00 AM	0.48
11/4/2025	1:30:00 AM	0.48
11/4/2025	1:45:00 AM	0.48
11/4/2025	2:00:00 AM	0.48
11/4/2025	2:15:00 AM	0.48
11/4/2025	2:30:00 AM	0.48
11/4/2025	2:45:00 AM	0.48
11/4/2025	3:00:00 AM	0.48
11/4/2025	3:15:00 AM	0.48
11/4/2025	3:30:00 AM	0.48
11/4/2025	3:45:00 AM	0.48
11/4/2025	4:00:00 AM	0.48
11/4/2025	4:15:00 AM	0.48
11/4/2025	4:30:00 AM	0.48
11/4/2025	4:45:00 AM	0.48
11/4/2025	5:00:00 AM	0.49
11/4/2025	5:15:00 AM	0.48
11/4/2025	5:30:00 AM	0.49
11/4/2025	5:45:00 AM	0.49
11/4/2025	6:00:00 AM	0.49
11/4/2025	6:15:00 AM	0.49
11/4/2025	6:30:00 AM	0.49
11/4/2025	6:45:00 AM	0.49
11/4/2025	7:00:00 AM	0.49
11/4/2025	7:15:00 AM	0.49
11/4/2025	7:30:00 AM	0.49
11/4/2025	7:45:00 AM	0.49
11/4/2025	8:00:00 AM	0.49
11/4/2025	8:15:00 AM	0.49

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/4/2025	8:30:00 AM	0.49
11/4/2025	8:45:00 AM	0.49
11/4/2025	9:00:00 AM	0.49
11/4/2025	9:15:00 AM	0.49
11/4/2025	9:30:00 AM	0.49
11/4/2025	9:45:00 AM	0.49
11/4/2025	10:00:00 AM	0.49
11/4/2025	10:15:00 AM	0.49
11/4/2025	10:30:00 AM	0.5
11/4/2025	10:45:00 AM	0.5
11/4/2025	11:00:00 AM	0.5
11/4/2025	11:15:00 AM	0.5
11/4/2025	11:30:00 AM	0.5
11/4/2025	11:45:00 AM	0.5
11/4/2025	12:00:00 PM	0.5
11/4/2025	12:15:00 PM	0.5
11/4/2025	12:30:00 PM	0.5
11/4/2025	12:45:00 PM	0.5
11/4/2025	1:00:00 PM	0.5
11/4/2025	1:15:00 PM	0.5
11/4/2025	1:30:00 PM	0.5
11/4/2025	1:45:00 PM	0.5
11/4/2025	2:00:00 PM	0.5
11/4/2025	2:15:00 PM	0.5
11/4/2025	2:30:00 PM	0.5
11/4/2025	2:45:00 PM	0.5
11/4/2025	3:00:00 PM	0.5
11/4/2025	3:15:00 PM	0.5
11/4/2025	3:30:00 PM	0.5
11/4/2025	3:45:00 PM	0.5
11/4/2025	4:00:00 PM	0.5
11/4/2025	4:15:00 PM	0.5
11/4/2025	4:30:00 PM	0.5
11/4/2025	4:45:00 PM	0.5
11/4/2025	5:00:00 PM	0.5
11/4/2025	5:15:00 PM	0.5
11/4/2025	5:30:00 PM	0.5
11/4/2025	5:45:00 PM	0.5
11/4/2025	6:00:00 PM	0.5
11/4/2025	6:15:00 PM	0.5
11/4/2025	6:30:00 PM	0.51
11/4/2025	6:45:00 PM	0.51
11/4/2025	7:00:00 PM	0.51
11/4/2025	7:15:00 PM	0.51
11/4/2025	7:30:00 PM	0.51
11/4/2025	7:45:00 PM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/4/2025	8:00:00 PM	0.51
11/4/2025	8:15:00 PM	0.51
11/4/2025	8:30:00 PM	0.51
11/4/2025	8:45:00 PM	0.51
11/4/2025	9:00:00 PM	0.51
11/4/2025	9:15:00 PM	0.51
11/4/2025	9:30:00 PM	0.51
11/4/2025	9:45:00 PM	0.51
11/4/2025	10:00:00 PM	0.51
11/4/2025	10:15:00 PM	0.51
11/4/2025	10:30:00 PM	0.51
11/4/2025	10:45:00 PM	0.51
11/4/2025	11:00:00 PM	0.51
11/4/2025	11:15:00 PM	0.51
11/4/2025	11:30:00 PM	0.51
11/4/2025	11:45:00 PM	0.51
11/5/2025	12:00:00 AM	0.51
11/5/2025	12:15:00 AM	0.51
11/5/2025	12:30:00 AM	0.51
11/5/2025	12:45:00 AM	0.51
11/5/2025	1:00:00 AM	0.51
11/5/2025	1:15:00 AM	0.51
11/5/2025	1:30:00 AM	0.51
11/5/2025	1:45:00 AM	0.51
11/5/2025	2:00:00 AM	0.51
11/5/2025	2:15:00 AM	0.51
11/5/2025	2:30:00 AM	0.51
11/5/2025	2:45:00 AM	0.51
11/5/2025	3:00:00 AM	0.51
11/5/2025	3:15:00 AM	0.51
11/5/2025	3:30:00 AM	0.51
11/5/2025	3:45:00 AM	0.51
11/5/2025	4:00:00 AM	0.51
11/5/2025	4:15:00 AM	0.51
11/5/2025	4:30:00 AM	0.51
11/5/2025	4:45:00 AM	0.51
11/5/2025	5:00:00 AM	0.51
11/5/2025	5:15:00 AM	0.51
11/5/2025	5:30:00 AM	0.51
11/5/2025	5:45:00 AM	0.51
11/5/2025	6:00:00 AM	0.51
11/5/2025	6:15:00 AM	0.51
11/5/2025	6:30:00 AM	0.51
11/5/2025	6:45:00 AM	0.51
11/5/2025	7:00:00 AM	0.51
11/5/2025	7:15:00 AM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/5/2025	7:30:00 AM	0.51
11/5/2025	7:45:00 AM	0.51
11/5/2025	8:00:00 AM	0.51
11/5/2025	8:15:00 AM	0.51
11/5/2025	8:30:00 AM	0.51
11/5/2025	8:45:00 AM	0.51
11/5/2025	9:00:00 AM	0.51
11/5/2025	9:15:00 AM	0.51
11/5/2025	9:30:00 AM	0.51
11/5/2025	9:45:00 AM	0.51
11/5/2025	10:00:00 AM	0.51
11/5/2025	10:15:00 AM	0.51
11/5/2025	10:30:00 AM	0.51
11/5/2025	10:45:00 AM	0.51
11/5/2025	11:00:00 AM	0.51
11/5/2025	11:15:00 AM	0.51
11/5/2025	11:30:00 AM	0.51
11/5/2025	11:45:00 AM	0.51
11/5/2025	12:00:00 PM	0.51
11/5/2025	12:15:00 PM	0.51
11/5/2025	12:30:00 PM	0.51
11/5/2025	12:45:00 PM	0.51
11/5/2025	1:00:00 PM	0.51
11/5/2025	1:15:00 PM	0.51
11/5/2025	1:30:00 PM	0.51
11/5/2025	1:45:00 PM	0.51
11/5/2025	2:00:00 PM	0.51
11/5/2025	2:15:00 PM	0.51
11/5/2025	2:30:00 PM	0.51
11/5/2025	2:45:00 PM	0.51
11/5/2025	3:00:00 PM	0.51
11/5/2025	3:15:00 PM	0.51
11/5/2025	3:30:00 PM	0.51
11/5/2025	3:45:00 PM	0.51
11/5/2025	4:00:00 PM	0.51
11/5/2025	4:15:00 PM	0.51
11/5/2025	4:30:00 PM	0.51
11/5/2025	4:45:00 PM	0.51
11/5/2025	5:00:00 PM	0.51
11/5/2025	5:15:00 PM	0.51
11/5/2025	5:30:00 PM	0.51
11/5/2025	5:45:00 PM	0.51
11/5/2025	6:00:00 PM	0.51
11/5/2025	6:15:00 PM	0.51
11/5/2025	6:30:00 PM	0.51
11/5/2025	6:45:00 PM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/5/2025	7:00:00 PM	0.51
11/5/2025	7:15:00 PM	0.51
11/5/2025	7:30:00 PM	0.51
11/5/2025	7:45:00 PM	0.51
11/5/2025	8:00:00 PM	0.51
11/5/2025	8:15:00 PM	0.51
11/5/2025	8:30:00 PM	0.51
11/5/2025	8:45:00 PM	0.51
11/5/2025	9:00:00 PM	0.51
11/5/2025	9:15:00 PM	0.51
11/5/2025	9:30:00 PM	0.51
11/5/2025	9:45:00 PM	0.51
11/5/2025	10:00:00 PM	0.51
11/5/2025	10:15:00 PM	0.51
11/5/2025	10:30:00 PM	0.51
11/5/2025	10:45:00 PM	0.51
11/5/2025	11:00:00 PM	0.51
11/5/2025	11:15:00 PM	0.51
11/5/2025	11:30:00 PM	0.51
11/5/2025	11:45:00 PM	0.51
11/6/2025	12:00:00 AM	0.51
11/6/2025	12:15:00 AM	0.51
11/6/2025	12:30:00 AM	0.51
11/6/2025	12:45:00 AM	0.51
11/6/2025	1:00:00 AM	0.51
11/6/2025	1:15:00 AM	0.51
11/6/2025	1:30:00 AM	0.51
11/6/2025	1:45:00 AM	0.51
11/6/2025	2:00:00 AM	0.51
11/6/2025	2:15:00 AM	0.51
11/6/2025	2:30:00 AM	0.51
11/6/2025	2:45:00 AM	0.51
11/6/2025	3:00:00 AM	0.51
11/6/2025	3:15:00 AM	0.51
11/6/2025	3:30:00 AM	0.51
11/6/2025	3:45:00 AM	0.51
11/6/2025	4:00:00 AM	0.51
11/6/2025	4:15:00 AM	0.51
11/6/2025	4:30:00 AM	0.51
11/6/2025	4:45:00 AM	0.51
11/6/2025	5:00:00 AM	0.51
11/6/2025	5:15:00 AM	0.51
11/6/2025	5:30:00 AM	0.51
11/6/2025	5:45:00 AM	0.51
11/6/2025	6:00:00 AM	0.5
11/6/2025	6:15:00 AM	0.5

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/6/2025	6:30:00 AM	0.5
11/6/2025	6:45:00 AM	0.5
11/6/2025	7:00:00 AM	0.5
11/6/2025	7:15:00 AM	0.5
11/6/2025	7:30:00 AM	0.5
11/6/2025	7:45:00 AM	0.5
11/6/2025	8:00:00 AM	0.5
11/6/2025	8:15:00 AM	0.5
11/6/2025	8:30:00 AM	0.5
11/6/2025	8:45:00 AM	0.5
11/6/2025	9:00:00 AM	0.5
11/6/2025	9:15:00 AM	0.5
11/6/2025	9:30:00 AM	0.5
11/6/2025	9:45:00 AM	0.5
11/6/2025	10:00:00 AM	0.5
11/6/2025	10:15:00 AM	0.5
11/6/2025	10:30:00 AM	0.5
11/6/2025	10:45:00 AM	0.5
11/6/2025	11:00:00 AM	0.5
11/6/2025	11:15:00 AM	0.5
11/6/2025	11:30:00 AM	0.5
11/6/2025	11:45:00 AM	0.5
11/6/2025	12:00:00 PM	0.5
11/6/2025	12:15:00 PM	0.5
11/6/2025	12:30:00 PM	0.5
11/6/2025	12:45:00 PM	0.5
11/6/2025	1:00:00 PM	0.5
11/6/2025	1:15:00 PM	0.5
11/6/2025	1:30:00 PM	0.5
11/6/2025	1:45:00 PM	0.5
11/6/2025	2:00:00 PM	0.5
11/6/2025	2:15:00 PM	0.5
11/6/2025	2:30:00 PM	0.5
11/6/2025	2:45:00 PM	0.5
11/6/2025	3:00:00 PM	0.5
11/6/2025	3:15:00 PM	0.5
11/6/2025	3:30:00 PM	0.5
11/6/2025	3:45:00 PM	0.5
11/6/2025	4:00:00 PM	0.5
11/6/2025	4:15:00 PM	0.5
11/6/2025	4:30:00 PM	0.5
11/6/2025	4:45:00 PM	0.5
11/6/2025	5:00:00 PM	0.5
11/6/2025	5:15:00 PM	0.5
11/6/2025	5:30:00 PM	0.5
11/6/2025	5:45:00 PM	0.5

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/6/2025	6:00:00 PM	0.5
11/6/2025	6:15:00 PM	0.5
11/6/2025	6:30:00 PM	0.5
11/6/2025	6:45:00 PM	0.5
11/6/2025	7:00:00 PM	0.5
11/6/2025	7:15:00 PM	0.5
11/6/2025	7:30:00 PM	0.5
11/6/2025	7:45:00 PM	0.5
11/6/2025	8:00:00 PM	0.5
11/6/2025	8:15:00 PM	0.5
11/6/2025	8:30:00 PM	0.5
11/6/2025	8:45:00 PM	0.5
11/6/2025	9:00:00 PM	0.5
11/6/2025	9:15:00 PM	0.5
11/6/2025	9:30:00 PM	0.5
11/6/2025	9:45:00 PM	0.5
11/6/2025	10:00:00 PM	0.5
11/6/2025	10:15:00 PM	0.5
11/6/2025	10:30:00 PM	0.5
11/6/2025	10:45:00 PM	0.5
11/6/2025	11:00:00 PM	0.5
11/6/2025	11:15:00 PM	0.5
11/6/2025	11:30:00 PM	0.51
11/6/2025	11:45:00 PM	0.51
11/7/2025	12:00:00 AM	0.51
11/7/2025	12:15:00 AM	0.51
11/7/2025	12:30:00 AM	0.51
11/7/2025	12:45:00 AM	0.51
11/7/2025	1:00:00 AM	0.51
11/7/2025	1:15:00 AM	0.51
11/7/2025	1:30:00 AM	0.51
11/7/2025	1:45:00 AM	0.51
11/7/2025	2:00:00 AM	0.51
11/7/2025	2:15:00 AM	0.51
11/7/2025	2:30:00 AM	0.51
11/7/2025	2:45:00 AM	0.51
11/7/2025	3:00:00 AM	0.51
11/7/2025	3:15:00 AM	0.51
11/7/2025	3:30:00 AM	0.51
11/7/2025	3:45:00 AM	0.51
11/7/2025	4:00:00 AM	0.51
11/7/2025	4:15:00 AM	0.51
11/7/2025	4:30:00 AM	0.51
11/7/2025	4:45:00 AM	0.51
11/7/2025	5:00:00 AM	0.51
11/7/2025	5:15:00 AM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/7/2025	5:30:00 AM	0.51
11/7/2025	5:45:00 AM	0.51
11/7/2025	6:00:00 AM	0.51
11/7/2025	6:15:00 AM	0.51
11/7/2025	6:30:00 AM	0.51
11/7/2025	6:45:00 AM	0.51
11/7/2025	7:00:00 AM	0.51
11/7/2025	7:15:00 AM	0.51
11/7/2025	7:30:00 AM	0.51
11/7/2025	7:45:00 AM	0.51
11/7/2025	8:00:00 AM	0.51
11/7/2025	8:15:00 AM	0.51
11/7/2025	8:30:00 AM	0.51
11/7/2025	8:45:00 AM	0.51
11/7/2025	9:00:00 AM	0.51
11/7/2025	9:15:00 AM	0.51
11/7/2025	9:30:00 AM	0.51
11/7/2025	9:45:00 AM	0.51
11/7/2025	10:00:00 AM	0.51
11/7/2025	10:15:00 AM	0.51
11/7/2025	10:30:00 AM	0.51
11/7/2025	10:45:00 AM	0.51
11/7/2025	11:00:00 AM	0.51
11/7/2025	11:15:00 AM	0.51
11/7/2025	11:30:00 AM	0.51
11/7/2025	11:45:00 AM	0.51
11/7/2025	12:00:00 PM	0.51
11/7/2025	12:15:00 PM	0.51
11/7/2025	12:30:00 PM	0.51
11/7/2025	12:45:00 PM	0.51
11/7/2025	1:00:00 PM	0.51
11/7/2025	1:15:00 PM	0.51
11/7/2025	1:30:00 PM	0.51
11/7/2025	1:45:00 PM	0.51
11/7/2025	2:00:00 PM	0.51
11/7/2025	2:15:00 PM	0.51
11/7/2025	2:30:00 PM	0.51
11/7/2025	2:45:00 PM	0.51
11/7/2025	3:00:00 PM	0.51
11/7/2025	3:15:00 PM	0.51
11/7/2025	3:30:00 PM	0.51
11/7/2025	3:45:00 PM	0.51
11/7/2025	4:00:00 PM	0.51
11/7/2025	4:15:00 PM	0.51
11/7/2025	4:30:00 PM	0.51
11/7/2025	4:45:00 PM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/7/2025	5:00:00 PM	0.51
11/7/2025	5:15:00 PM	0.51
11/7/2025	5:30:00 PM	0.51
11/7/2025	5:45:00 PM	0.52
11/7/2025	6:00:00 PM	0.51
11/7/2025	6:15:00 PM	0.51
11/7/2025	6:30:00 PM	0.51
11/7/2025	6:45:00 PM	0.52
11/7/2025	7:00:00 PM	0.52
11/7/2025	7:15:00 PM	0.51
11/7/2025	7:30:00 PM	0.52
11/7/2025	7:45:00 PM	0.52
11/7/2025	8:00:00 PM	0.51
11/7/2025	8:15:00 PM	0.52
11/7/2025	8:30:00 PM	0.52
11/7/2025	8:45:00 PM	0.52
11/7/2025	9:00:00 PM	0.52
11/7/2025	9:15:00 PM	0.52
11/7/2025	9:30:00 PM	0.52
11/7/2025	9:45:00 PM	0.52
11/7/2025	10:00:00 PM	0.52
11/7/2025	10:15:00 PM	0.52
11/7/2025	10:30:00 PM	0.52
11/7/2025	10:45:00 PM	0.52
11/7/2025	11:00:00 PM	0.52
11/7/2025	11:15:00 PM	0.52
11/7/2025	11:30:00 PM	0.52
11/7/2025	11:45:00 PM	0.52
11/8/2025	12:00:00 AM	0.51
11/8/2025	12:15:00 AM	0.51
11/8/2025	12:30:00 AM	0.51
11/8/2025	12:45:00 AM	0.51
11/8/2025	1:00:00 AM	0.51
11/8/2025	1:15:00 AM	0.51
11/8/2025	1:30:00 AM	0.51
11/8/2025	1:45:00 AM	0.51
11/8/2025	2:00:00 AM	0.51
11/8/2025	2:15:00 AM	0.51
11/8/2025	2:30:00 AM	0.51
11/8/2025	2:45:00 AM	0.51
11/8/2025	3:00:00 AM	0.51
11/8/2025	3:15:00 AM	0.51
11/8/2025	3:30:00 AM	0.51
11/8/2025	3:45:00 AM	0.51
11/8/2025	4:00:00 AM	0.51
11/8/2025	4:15:00 AM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/8/2025	4:30:00 AM	0.51
11/8/2025	4:45:00 AM	0.51
11/8/2025	5:00:00 AM	0.51
11/8/2025	5:15:00 AM	0.51
11/8/2025	5:30:00 AM	0.51
11/8/2025	5:45:00 AM	0.51
11/8/2025	6:00:00 AM	0.51
11/8/2025	6:15:00 AM	0.51
11/8/2025	6:30:00 AM	0.51
11/8/2025	6:45:00 AM	0.51
11/8/2025	7:00:00 AM	0.51
11/8/2025	7:15:00 AM	0.51
11/8/2025	7:30:00 AM	0.51
11/8/2025	7:45:00 AM	0.51
11/8/2025	8:00:00 AM	0.51
11/8/2025	8:15:00 AM	0.51
11/8/2025	8:30:00 AM	0.51
11/8/2025	8:45:00 AM	0.51
11/8/2025	9:00:00 AM	0.51
11/8/2025	9:15:00 AM	0.51
11/8/2025	9:30:00 AM	0.51
11/8/2025	9:45:00 AM	0.51
11/8/2025	10:00:00 AM	0.5
11/8/2025	10:15:00 AM	0.5
11/8/2025	10:30:00 AM	0.5
11/8/2025	10:45:00 AM	0.5
11/8/2025	11:00:00 AM	0.5
11/8/2025	11:15:00 AM	0.5
11/8/2025	11:30:00 AM	0.5
11/8/2025	11:45:00 AM	0.5
11/8/2025	12:00:00 PM	0.5
11/8/2025	12:15:00 PM	0.5
11/8/2025	12:30:00 PM	0.5
11/8/2025	12:45:00 PM	0.5
11/8/2025	1:00:00 PM	0.5
11/8/2025	1:15:00 PM	0.5
11/8/2025	1:30:00 PM	0.5
11/8/2025	1:45:00 PM	0.5
11/8/2025	2:00:00 PM	0.5
11/8/2025	2:15:00 PM	0.5
11/8/2025	2:30:00 PM	0.5
11/8/2025	2:45:00 PM	0.5
11/8/2025	3:00:00 PM	0.5
11/8/2025	3:15:00 PM	0.5
11/8/2025	3:30:00 PM	0.49
11/8/2025	3:45:00 PM	0.49

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/8/2025	4:00:00 PM	0.49
11/8/2025	4:15:00 PM	0.49
11/8/2025	4:30:00 PM	0.49
11/8/2025	4:45:00 PM	0.49
11/8/2025	5:00:00 PM	0.49
11/8/2025	5:15:00 PM	0.49
11/8/2025	5:30:00 PM	0.49
11/8/2025	5:45:00 PM	0.49
11/8/2025	6:00:00 PM	0.49
11/8/2025	6:15:00 PM	0.49
11/8/2025	6:30:00 PM	0.49
11/8/2025	6:45:00 PM	0.49
11/8/2025	7:00:00 PM	0.49
11/8/2025	7:15:00 PM	0.49
11/8/2025	7:30:00 PM	0.49
11/8/2025	7:45:00 PM	0.49
11/8/2025	8:00:00 PM	0.49
11/8/2025	8:15:00 PM	0.49
11/8/2025	8:30:00 PM	0.49
11/8/2025	8:45:00 PM	0.49
11/8/2025	9:00:00 PM	0.49
11/8/2025	9:15:00 PM	0.49
11/8/2025	9:30:00 PM	0.49
11/8/2025	9:45:00 PM	0.49
11/8/2025	10:00:00 PM	0.49
11/8/2025	10:15:00 PM	0.49
11/8/2025	10:30:00 PM	0.49
11/8/2025	10:45:00 PM	0.49
11/8/2025	11:00:00 PM	0.49
11/8/2025	11:15:00 PM	0.49
11/8/2025	11:30:00 PM	0.49
11/8/2025	11:45:00 PM	0.49
11/9/2025	12:00:00 AM	0.49
11/9/2025	12:15:00 AM	0.49
11/9/2025	12:30:00 AM	0.49
11/9/2025	12:45:00 AM	0.49
11/9/2025	1:00:00 AM	0.49
11/9/2025	1:15:00 AM	0.49
11/9/2025	1:30:00 AM	0.49
11/9/2025	1:45:00 AM	0.49
11/9/2025	2:00:00 AM	0.49
11/9/2025	2:15:00 AM	0.49
11/9/2025	2:30:00 AM	0.49
11/9/2025	2:45:00 AM	0.49
11/9/2025	3:00:00 AM	0.49
11/9/2025	3:15:00 AM	0.49

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/9/2025	3:30:00 AM	0.49
11/9/2025	3:45:00 AM	0.49
11/9/2025	4:00:00 AM	0.49
11/9/2025	4:15:00 AM	0.49
11/9/2025	4:30:00 AM	0.49
11/9/2025	4:45:00 AM	0.49
11/9/2025	5:00:00 AM	0.49
11/9/2025	5:15:00 AM	0.49
11/9/2025	5:30:00 AM	0.49
11/9/2025	5:45:00 AM	0.49
11/9/2025	6:00:00 AM	0.49
11/9/2025	6:15:00 AM	0.49
11/9/2025	6:30:00 AM	0.49
11/9/2025	6:45:00 AM	0.48
11/9/2025	7:00:00 AM	0.49
11/9/2025	7:15:00 AM	0.49
11/9/2025	7:30:00 AM	0.48
11/9/2025	7:45:00 AM	0.48
11/9/2025	8:00:00 AM	0.48
11/9/2025	8:15:00 AM	0.48
11/9/2025	8:30:00 AM	0.48
11/9/2025	8:45:00 AM	0.48
11/9/2025	9:00:00 AM	0.48
11/9/2025	9:15:00 AM	0.48
11/9/2025	9:30:00 AM	0.48
11/9/2025	9:45:00 AM	0.48
11/9/2025	10:00:00 AM	0.48
11/9/2025	10:15:00 AM	0.48
11/9/2025	10:30:00 AM	0.48
11/9/2025	10:45:00 AM	0.48
11/9/2025	11:00:00 AM	0.48
11/9/2025	11:15:00 AM	0.48
11/9/2025	11:30:00 AM	0.48
11/9/2025	11:45:00 AM	0.48
11/9/2025	12:00:00 PM	0.48
11/9/2025	12:15:00 PM	0.48
11/9/2025	12:30:00 PM	0.48
11/9/2025	12:45:00 PM	0.48
11/9/2025	1:00:00 PM	0.48
11/9/2025	1:15:00 PM	0.48
11/9/2025	1:30:00 PM	0.48
11/9/2025	1:45:00 PM	0.48
11/9/2025	2:00:00 PM	0.48
11/9/2025	2:15:00 PM	0.48
11/9/2025	2:30:00 PM	0.48
11/9/2025	2:45:00 PM	0.48

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/9/2025	3:00:00 PM	0.48
11/9/2025	3:15:00 PM	0.48
11/9/2025	3:30:00 PM	0.48
11/9/2025	3:45:00 PM	0.48
11/9/2025	4:00:00 PM	0.48
11/9/2025	4:15:00 PM	0.48
11/9/2025	4:30:00 PM	0.48
11/9/2025	4:45:00 PM	0.48
11/9/2025	5:00:00 PM	0.48
11/9/2025	5:15:00 PM	0.48
11/9/2025	5:30:00 PM	0.48
11/9/2025	5:45:00 PM	0.48
11/9/2025	6:00:00 PM	0.48
11/9/2025	6:15:00 PM	0.48
11/9/2025	6:30:00 PM	0.48
11/9/2025	6:45:00 PM	0.48
11/9/2025	7:00:00 PM	0.47
11/9/2025	7:15:00 PM	0.47
11/9/2025	7:30:00 PM	0.47
11/9/2025	7:45:00 PM	0.47
11/9/2025	8:00:00 PM	0.47
11/9/2025	8:15:00 PM	0.47
11/9/2025	8:30:00 PM	0.47
11/9/2025	8:45:00 PM	0.47
11/9/2025	9:00:00 PM	0.47
11/9/2025	9:15:00 PM	0.47
11/9/2025	9:30:00 PM	0.47
11/9/2025	9:45:00 PM	0.47
11/9/2025	10:00:00 PM	0.47
11/9/2025	10:15:00 PM	0.47
11/9/2025	10:30:00 PM	0.47
11/9/2025	10:45:00 PM	0.47
11/9/2025	11:00:00 PM	0.47
11/9/2025	11:15:00 PM	0.47
11/9/2025	11:30:00 PM	0.47
11/9/2025	11:45:00 PM	0.47
11/10/2025	12:00:00 AM	0.47
11/10/2025	12:15:00 AM	0.47
11/10/2025	12:30:00 AM	0.47
11/10/2025	12:45:00 AM	0.47
11/10/2025	1:00:00 AM	0.47
11/10/2025	1:15:00 AM	0.47
11/10/2025	1:30:00 AM	0.47
11/10/2025	1:45:00 AM	0.47
11/10/2025	2:00:00 AM	0.47
11/10/2025	2:15:00 AM	0.47

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/10/2025	2:30:00 AM	0.47
11/10/2025	2:45:00 AM	0.47
11/10/2025	3:00:00 AM	0.47
11/10/2025	3:15:00 AM	0.47
11/10/2025	3:30:00 AM	0.47
11/10/2025	3:45:00 AM	0.47
11/10/2025	4:00:00 AM	0.47
11/10/2025	4:15:00 AM	0.47
11/10/2025	4:30:00 AM	0.47
11/10/2025	4:45:00 AM	0.47
11/10/2025	5:00:00 AM	0.47
11/10/2025	5:15:00 AM	0.46
11/10/2025	5:30:00 AM	0.46
11/10/2025	5:45:00 AM	0.47
11/10/2025	6:00:00 AM	0.46
11/10/2025	6:15:00 AM	0.46
11/10/2025	6:30:00 AM	0.46
11/10/2025	6:45:00 AM	0.46
11/10/2025	7:00:00 AM	0.46
11/10/2025	7:15:00 AM	0.46
11/10/2025	7:30:00 AM	0.46
11/10/2025	7:45:00 AM	0.46
11/10/2025	8:00:00 AM	0.46
11/10/2025	8:15:00 AM	0.46
11/10/2025	8:30:00 AM	0.46
11/10/2025	8:45:00 AM	0.46
11/10/2025	9:00:00 AM	0.46
11/10/2025	9:15:00 AM	0.46
11/10/2025	9:30:00 AM	0.46
11/10/2025	9:45:00 AM	0.46
11/10/2025	10:00:00 AM	0.46
11/10/2025	10:15:00 AM	0.46
11/10/2025	10:30:00 AM	0.46
11/10/2025	10:45:00 AM	0.46
11/10/2025	11:00:00 AM	0.46
11/10/2025	11:15:00 AM	0.46
11/10/2025	11:30:00 AM	0.46
11/10/2025	11:45:00 AM	0.46
11/10/2025	12:00:00 PM	0.46
11/10/2025	12:15:00 PM	0.46
11/10/2025	12:30:00 PM	0.46
11/10/2025	12:45:00 PM	0.46
11/10/2025	1:00:00 PM	0.46
11/10/2025	1:15:00 PM	0.46
11/10/2025	1:30:00 PM	0.46
11/10/2025	1:45:00 PM	0.46

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/10/2025	2:00:00 PM	0.46
11/10/2025	2:15:00 PM	0.46
11/10/2025	2:30:00 PM	0.46
11/10/2025	2:45:00 PM	0.46
11/10/2025	3:00:00 PM	0.46
11/10/2025	3:15:00 PM	0.46
11/10/2025	3:30:00 PM	0.46
11/10/2025	3:45:00 PM	0.46
11/10/2025	4:00:00 PM	0.46
11/10/2025	4:15:00 PM	0.46
11/10/2025	4:30:00 PM	0.46
11/10/2025	4:45:00 PM	0.46
11/10/2025	5:00:00 PM	0.46
11/10/2025	5:15:00 PM	0.46
11/10/2025	5:30:00 PM	0.47
11/10/2025	5:45:00 PM	0.47
11/10/2025	6:00:00 PM	0.47
11/10/2025	6:15:00 PM	0.47
11/10/2025	6:30:00 PM	0.47
11/10/2025	6:45:00 PM	0.47
11/10/2025	7:00:00 PM	0.47
11/10/2025	7:15:00 PM	0.47
11/10/2025	7:30:00 PM	0.47
11/10/2025	7:45:00 PM	0.47
11/10/2025	8:00:00 PM	0.48
11/10/2025	8:15:00 PM	0.48
11/10/2025	8:30:00 PM	0.48
11/10/2025	8:45:00 PM	0.48
11/10/2025	9:00:00 PM	0.48
11/10/2025	9:15:00 PM	0.48
11/10/2025	9:30:00 PM	0.48
11/10/2025	9:45:00 PM	0.48
11/10/2025	10:00:00 PM	0.48
11/10/2025	10:15:00 PM	0.49
11/10/2025	10:30:00 PM	0.49
11/10/2025	10:45:00 PM	0.49
11/10/2025	11:00:00 PM	0.49
11/10/2025	11:15:00 PM	0.49
11/10/2025	11:30:00 PM	0.49
11/10/2025	11:45:00 PM	0.49
11/11/2025	12:00:00 AM	0.49
11/11/2025	12:15:00 AM	0.49
11/11/2025	12:30:00 AM	0.49
11/11/2025	12:45:00 AM	0.49
11/11/2025	1:00:00 AM	0.49
11/11/2025	1:15:00 AM	0.49

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/11/2025	1:30:00 AM	0.49
11/11/2025	1:45:00 AM	0.5
11/11/2025	2:00:00 AM	0.5
11/11/2025	2:15:00 AM	0.5
11/11/2025	2:30:00 AM	0.5
11/11/2025	2:45:00 AM	0.5
11/11/2025	3:00:00 AM	0.5
11/11/2025	3:15:00 AM	0.5
11/11/2025	3:30:00 AM	0.5
11/11/2025	3:45:00 AM	0.5
11/11/2025	4:00:00 AM	0.5
11/11/2025	4:15:00 AM	0.5
11/11/2025	4:30:00 AM	0.5
11/11/2025	4:45:00 AM	0.5
11/11/2025	5:00:00 AM	0.5
11/11/2025	5:15:00 AM	0.5
11/11/2025	5:30:00 AM	0.5
11/11/2025	5:45:00 AM	0.5
11/11/2025	6:00:00 AM	0.5
11/11/2025	6:15:00 AM	0.5
11/11/2025	6:30:00 AM	0.5
11/11/2025	6:45:00 AM	0.5
11/11/2025	7:00:00 AM	0.5
11/11/2025	7:15:00 AM	0.5
11/11/2025	7:30:00 AM	0.5
11/11/2025	7:45:00 AM	0.5
11/11/2025	8:00:00 AM	0.5
11/11/2025	8:15:00 AM	0.5
11/11/2025	8:30:00 AM	0.5
11/11/2025	8:45:00 AM	0.5
11/11/2025	9:00:00 AM	0.5
11/11/2025	9:15:00 AM	0.5
11/11/2025	9:30:00 AM	0.5
11/11/2025	9:45:00 AM	0.5
11/11/2025	10:00:00 AM	0.5
11/11/2025	10:15:00 AM	0.5
11/11/2025	10:30:00 AM	0.5
11/11/2025	10:45:00 AM	0.5
11/11/2025	11:00:00 AM	0.5
11/11/2025	11:15:00 AM	0.5
11/11/2025	11:30:00 AM	0.5
11/11/2025	11:45:00 AM	0.5
11/11/2025	12:00:00 PM	0.5
11/11/2025	12:15:00 PM	0.5
11/11/2025	12:30:00 PM	0.5
11/11/2025	12:45:00 PM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/11/2025	1:00:00 PM	0.51
11/11/2025	1:15:00 PM	0.51
11/11/2025	1:30:00 PM	0.51
11/11/2025	1:45:00 PM	0.51
11/11/2025	2:00:00 PM	0.51
11/11/2025	2:15:00 PM	0.51
11/11/2025	2:30:00 PM	0.51
11/11/2025	2:45:00 PM	0.51
11/11/2025	3:00:00 PM	0.51
11/11/2025	3:15:00 PM	0.51
11/11/2025	3:30:00 PM	0.51
11/11/2025	3:45:00 PM	0.51
11/11/2025	4:00:00 PM	0.51
11/11/2025	4:15:00 PM	0.51
11/11/2025	4:30:00 PM	0.51
11/11/2025	4:45:00 PM	0.51
11/11/2025	5:00:00 PM	0.51
11/11/2025	5:15:00 PM	0.51
11/11/2025	5:30:00 PM	0.51
11/11/2025	5:45:00 PM	0.51
11/11/2025	6:00:00 PM	0.51
11/11/2025	6:15:00 PM	0.52
11/11/2025	6:30:00 PM	0.51
11/11/2025	6:45:00 PM	0.52
11/11/2025	7:00:00 PM	0.52
11/11/2025	7:15:00 PM	0.52
11/11/2025	7:30:00 PM	0.52
11/11/2025	7:45:00 PM	0.52
11/11/2025	8:00:00 PM	0.52
11/11/2025	8:15:00 PM	0.52
11/11/2025	8:30:00 PM	0.52
11/11/2025	8:45:00 PM	0.52
11/11/2025	9:00:00 PM	0.52
11/11/2025	9:15:00 PM	0.52
11/11/2025	9:30:00 PM	0.52
11/11/2025	9:45:00 PM	0.52
11/11/2025	10:00:00 PM	0.52
11/11/2025	10:15:00 PM	0.52
11/11/2025	10:30:00 PM	0.52
11/11/2025	10:45:00 PM	0.53
11/11/2025	11:00:00 PM	0.53
11/11/2025	11:15:00 PM	0.53
11/11/2025	11:30:00 PM	0.53
11/11/2025	11:45:00 PM	0.53
11/12/2025	12:00:00 AM	0.53
11/12/2025	12:15:00 AM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/12/2025	12:30:00 AM	0.53
11/12/2025	12:45:00 AM	0.53
11/12/2025	1:00:00 AM	0.53
11/12/2025	1:15:00 AM	0.53
11/12/2025	1:30:00 AM	0.53
11/12/2025	1:45:00 AM	0.53
11/12/2025	2:00:00 AM	0.53
11/12/2025	2:15:00 AM	0.53
11/12/2025	2:30:00 AM	0.53
11/12/2025	2:45:00 AM	0.53
11/12/2025	3:00:00 AM	0.53
11/12/2025	3:15:00 AM	0.53
11/12/2025	3:30:00 AM	0.53
11/12/2025	3:45:00 AM	0.54
11/12/2025	4:00:00 AM	0.54
11/12/2025	4:15:00 AM	0.54
11/12/2025	4:30:00 AM	0.54
11/12/2025	4:45:00 AM	0.54
11/12/2025	5:00:00 AM	0.54
11/12/2025	5:15:00 AM	0.54
11/12/2025	5:30:00 AM	0.54
11/12/2025	5:45:00 AM	0.54
11/12/2025	6:00:00 AM	0.54
11/12/2025	6:15:00 AM	0.54
11/12/2025	6:30:00 AM	0.54
11/12/2025	6:45:00 AM	0.54
11/12/2025	7:00:00 AM	0.54
11/12/2025	7:15:00 AM	0.54
11/12/2025	7:30:00 AM	0.54
11/12/2025	7:45:00 AM	0.54
11/12/2025	8:00:00 AM	0.54
11/12/2025	8:15:00 AM	0.54
11/12/2025	8:30:00 AM	0.54
11/12/2025	8:45:00 AM	0.54
11/12/2025	9:00:00 AM	0.54
11/12/2025	9:15:00 AM	0.54
11/12/2025	9:30:00 AM	0.54
11/12/2025	9:45:00 AM	0.54
11/12/2025	10:00:00 AM	0.54
11/12/2025	10:15:00 AM	0.54
11/12/2025	10:30:00 AM	0.55
11/12/2025	10:45:00 AM	0.55
11/12/2025	11:00:00 AM	0.55
11/12/2025	11:15:00 AM	0.55
11/12/2025	11:30:00 AM	0.55
11/12/2025	11:45:00 AM	0.55

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/12/2025	12:00:00 PM	0.55
11/12/2025	12:15:00 PM	0.55
11/12/2025	12:30:00 PM	0.55
11/12/2025	12:45:00 PM	0.55
11/12/2025	1:00:00 PM	0.54
11/12/2025	1:15:00 PM	0.54
11/12/2025	1:30:00 PM	0.54
11/12/2025	1:45:00 PM	0.53
11/12/2025	2:00:00 PM	0.53
11/12/2025	2:15:00 PM	0.52
11/12/2025	2:30:00 PM	0.51
11/12/2025	2:45:00 PM	0.51
11/12/2025	3:00:00 PM	0.5
11/12/2025	3:15:00 PM	0.5
11/12/2025	3:30:00 PM	0.5
11/12/2025	3:45:00 PM	0.49
11/12/2025	4:00:00 PM	0.49
11/12/2025	4:15:00 PM	0.48
11/12/2025	4:30:00 PM	0.48
11/12/2025	4:45:00 PM	0.48
11/12/2025	5:00:00 PM	0.47
11/12/2025	5:15:00 PM	0.47
11/12/2025	5:30:00 PM	0.47
11/12/2025	5:45:00 PM	0.46
11/12/2025	6:00:00 PM	0.46
11/12/2025	6:15:00 PM	0.45
11/12/2025	6:30:00 PM	0.45
11/12/2025	6:45:00 PM	0.45
11/12/2025	7:00:00 PM	0.44
11/12/2025	7:15:00 PM	0.44
11/12/2025	7:30:00 PM	0.44
11/12/2025	7:45:00 PM	0.44
11/12/2025	8:00:00 PM	0.44
11/12/2025	8:15:00 PM	0.43
11/12/2025	8:30:00 PM	0.43
11/12/2025	8:45:00 PM	0.43
11/12/2025	9:00:00 PM	0.43
11/12/2025	9:15:00 PM	0.43
11/12/2025	9:30:00 PM	0.42
11/12/2025	9:45:00 PM	0.42
11/12/2025	10:00:00 PM	0.42
11/12/2025	10:15:00 PM	0.42
11/12/2025	10:30:00 PM	0.42
11/12/2025	10:45:00 PM	0.42
11/12/2025	11:00:00 PM	0.41
11/12/2025	11:15:00 PM	0.41

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/12/2025	11:30:00 PM	0.41
11/12/2025	11:45:00 PM	0.41
11/13/2025	12:00:00 AM	0.41
11/13/2025	12:15:00 AM	0.41
11/13/2025	12:30:00 AM	0.41
11/13/2025	12:45:00 AM	0.41
11/13/2025	1:00:00 AM	0.41
11/13/2025	1:15:00 AM	0.41
11/13/2025	1:30:00 AM	0.4
11/13/2025	1:45:00 AM	0.4
11/13/2025	2:00:00 AM	0.4
11/13/2025	2:15:00 AM	0.4
11/13/2025	2:30:00 AM	0.4
11/13/2025	2:45:00 AM	0.4
11/13/2025	3:00:00 AM	0.4
11/13/2025	3:15:00 AM	0.4
11/13/2025	3:30:00 AM	0.4
11/13/2025	3:45:00 AM	0.4
11/13/2025	4:00:00 AM	0.4
11/13/2025	4:15:00 AM	0.4
11/13/2025	4:30:00 AM	0.4
11/13/2025	4:45:00 AM	0.4
11/13/2025	5:00:00 AM	0.4
11/13/2025	5:15:00 AM	0.4
11/13/2025	5:30:00 AM	0.39
11/13/2025	5:45:00 AM	0.39
11/13/2025	6:00:00 AM	0.39
11/13/2025	6:15:00 AM	0.39
11/13/2025	6:30:00 AM	0.39
11/13/2025	6:45:00 AM	0.39
11/13/2025	7:00:00 AM	0.39
11/13/2025	7:15:00 AM	0.39
11/13/2025	7:30:00 AM	0.39
11/13/2025	7:45:00 AM	0.39
11/13/2025	8:00:00 AM	0.39
11/13/2025	8:15:00 AM	0.39
11/13/2025	8:30:00 AM	0.39
11/13/2025	8:45:00 AM	0.39
11/13/2025	9:00:00 AM	0.39
11/13/2025	9:15:00 AM	0.39
11/13/2025	9:30:00 AM	0.39
11/13/2025	9:45:00 AM	0.39
11/13/2025	10:00:00 AM	0.39
11/13/2025	10:15:00 AM	0.39
11/13/2025	10:30:00 AM	0.39
11/13/2025	10:45:00 AM	0.4

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/13/2025	11:00:00 AM	0.4
11/13/2025	11:15:00 AM	0.4
11/13/2025	11:30:00 AM	0.4
11/13/2025	11:45:00 AM	0.41
11/13/2025	12:00:00 PM	0.41
11/13/2025	12:15:00 PM	0.41
11/13/2025	12:30:00 PM	0.42
11/13/2025	12:45:00 PM	0.42
11/13/2025	1:00:00 PM	0.42
11/13/2025	1:15:00 PM	0.43
11/13/2025	1:30:00 PM	0.43
11/13/2025	1:45:00 PM	0.43
11/13/2025	2:00:00 PM	0.43
11/13/2025	2:15:00 PM	0.44
11/13/2025	2:30:00 PM	0.44
11/13/2025	2:45:00 PM	0.44
11/13/2025	3:00:00 PM	0.44
11/13/2025	3:15:00 PM	0.44
11/13/2025	3:30:00 PM	0.45
11/13/2025	3:45:00 PM	0.45
11/13/2025	4:00:00 PM	0.45
11/13/2025	4:15:00 PM	0.45
11/13/2025	4:30:00 PM	0.45
11/13/2025	4:45:00 PM	0.46
11/13/2025	5:00:00 PM	0.46
11/13/2025	5:15:00 PM	0.46
11/13/2025	5:30:00 PM	0.46
11/13/2025	5:45:00 PM	0.46
11/13/2025	6:00:00 PM	0.46
11/13/2025	6:15:00 PM	0.46
11/13/2025	6:30:00 PM	0.46
11/13/2025	6:45:00 PM	0.47
11/13/2025	7:00:00 PM	0.47
11/13/2025	7:15:00 PM	0.47
11/13/2025	7:30:00 PM	0.47
11/13/2025	7:45:00 PM	0.47
11/13/2025	8:00:00 PM	0.47
11/13/2025	8:15:00 PM	0.47
11/13/2025	8:30:00 PM	0.47
11/13/2025	8:45:00 PM	0.48
11/13/2025	9:00:00 PM	0.48
11/13/2025	9:15:00 PM	0.48
11/13/2025	9:30:00 PM	0.48
11/13/2025	9:45:00 PM	0.48
11/13/2025	10:00:00 PM	0.48
11/13/2025	10:15:00 PM	0.48

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/13/2025	10:30:00 PM	0.48
11/13/2025	10:45:00 PM	0.48
11/13/2025	11:00:00 PM	0.48
11/13/2025	11:15:00 PM	0.49
11/13/2025	11:30:00 PM	0.49
11/13/2025	11:45:00 PM	0.49
11/14/2025	12:00:00 AM	0.49
11/14/2025	12:15:00 AM	0.49
11/14/2025	12:30:00 AM	0.49
11/14/2025	12:45:00 AM	0.49
11/14/2025	1:00:00 AM	0.49
11/14/2025	1:15:00 AM	0.49
11/14/2025	1:30:00 AM	0.49
11/14/2025	1:45:00 AM	0.5
11/14/2025	2:00:00 AM	0.5
11/14/2025	2:15:00 AM	0.5
11/14/2025	2:30:00 AM	0.5
11/14/2025	2:45:00 AM	0.5
11/14/2025	3:00:00 AM	0.5
11/14/2025	3:15:00 AM	0.5
11/14/2025	3:30:00 AM	0.5
11/14/2025	3:45:00 AM	0.5
11/14/2025	4:00:00 AM	0.5
11/14/2025	4:15:00 AM	0.5
11/14/2025	4:30:00 AM	0.5
11/14/2025	4:45:00 AM	0.5
11/14/2025	5:00:00 AM	0.5
11/14/2025	5:15:00 AM	0.5
11/14/2025	5:30:00 AM	0.5
11/14/2025	5:45:00 AM	0.5
11/14/2025	6:00:00 AM	0.5
11/14/2025	6:15:00 AM	0.5
11/14/2025	6:30:00 AM	0.5
11/14/2025	6:45:00 AM	0.51
11/14/2025	7:00:00 AM	0.51
11/14/2025	7:15:00 AM	0.51
11/14/2025	7:30:00 AM	0.51
11/14/2025	7:45:00 AM	0.51
11/14/2025	8:00:00 AM	0.51
11/14/2025	8:15:00 AM	0.51
11/14/2025	8:30:00 AM	0.52
11/14/2025	8:45:00 AM	0.53
11/14/2025	9:00:00 AM	0.55
11/14/2025	9:15:00 AM	0.58
11/14/2025	9:30:00 AM	0.62
11/14/2025	9:45:00 AM	0.67

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/14/2025	10:00:00 AM	0.72
11/14/2025	10:15:00 AM	0.77
11/14/2025	10:30:00 AM	0.81
11/14/2025	10:45:00 AM	0.85
11/14/2025	11:00:00 AM	0.88
11/14/2025	11:15:00 AM	0.91
11/14/2025	11:30:00 AM	0.94
11/14/2025	11:45:00 AM	0.97
11/14/2025	12:00:00 PM	1
11/14/2025	12:15:00 PM	1.02
11/14/2025	12:30:00 PM	1.03
11/14/2025	12:45:00 PM	1.05
11/14/2025	1:00:00 PM	1.06
11/14/2025	1:15:00 PM	1.07
11/14/2025	1:30:00 PM	1.08
11/14/2025	1:45:00 PM	1.09
11/14/2025	2:00:00 PM	1.09
11/14/2025	2:15:00 PM	1.09
11/14/2025	2:30:00 PM	1.09
11/14/2025	2:45:00 PM	1.09
11/14/2025	3:00:00 PM	1.08
11/14/2025	3:15:00 PM	1.08
11/14/2025	3:30:00 PM	1.07
11/14/2025	3:45:00 PM	1.07
11/14/2025	4:00:00 PM	1.06
11/14/2025	4:15:00 PM	1.05
11/14/2025	4:30:00 PM	1.05
11/14/2025	4:45:00 PM	1.04
11/14/2025	5:00:00 PM	1.03
11/14/2025	5:15:00 PM	1.02
11/14/2025	5:30:00 PM	1.01
11/14/2025	5:45:00 PM	1.01
11/14/2025	6:00:00 PM	1
11/14/2025	6:15:00 PM	0.99
11/14/2025	6:30:00 PM	0.98
11/14/2025	6:45:00 PM	0.97
11/14/2025	7:00:00 PM	0.96
11/14/2025	7:15:00 PM	0.95
11/14/2025	7:30:00 PM	0.94
11/14/2025	7:45:00 PM	0.93
11/14/2025	8:00:00 PM	0.91
11/14/2025	8:15:00 PM	0.9
11/14/2025	8:30:00 PM	0.89
11/14/2025	8:45:00 PM	0.88
11/14/2025	9:00:00 PM	0.87
11/14/2025	9:15:00 PM	0.86

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/14/2025	9:30:00 PM	0.85
11/14/2025	9:45:00 PM	0.84
11/14/2025	10:00:00 PM	0.84
11/14/2025	10:15:00 PM	0.83
11/14/2025	10:30:00 PM	0.82
11/14/2025	10:45:00 PM	0.81
11/14/2025	11:00:00 PM	0.8
11/14/2025	11:15:00 PM	0.8
11/14/2025	11:30:00 PM	0.79
11/14/2025	11:45:00 PM	0.78
11/15/2025	12:00:00 AM	0.77
11/15/2025	12:15:00 AM	0.77
11/15/2025	12:30:00 AM	0.76
11/15/2025	12:45:00 AM	0.75
11/15/2025	1:00:00 AM	0.75
11/15/2025	1:15:00 AM	0.74
11/15/2025	1:30:00 AM	0.73
11/15/2025	1:45:00 AM	0.73
11/15/2025	2:00:00 AM	0.72
11/15/2025	2:15:00 AM	0.72
11/15/2025	2:30:00 AM	0.71
11/15/2025	2:45:00 AM	0.71
11/15/2025	3:00:00 AM	0.7
11/15/2025	3:15:00 AM	0.69
11/15/2025	3:30:00 AM	0.69
11/15/2025	3:45:00 AM	0.68
11/15/2025	4:00:00 AM	0.68
11/15/2025	4:15:00 AM	0.67
11/15/2025	4:30:00 AM	0.67
11/15/2025	4:45:00 AM	0.66
11/15/2025	5:00:00 AM	0.66
11/15/2025	5:15:00 AM	0.65
11/15/2025	5:30:00 AM	0.65
11/15/2025	5:45:00 AM	0.65
11/15/2025	6:00:00 AM	0.64
11/15/2025	6:15:00 AM	0.64
11/15/2025	6:30:00 AM	0.63
11/15/2025	6:45:00 AM	0.63
11/15/2025	7:00:00 AM	0.62
11/15/2025	7:15:00 AM	0.62
11/15/2025	7:30:00 AM	0.62
11/15/2025	7:45:00 AM	0.61
11/15/2025	8:00:00 AM	0.61
11/15/2025	8:15:00 AM	0.61
11/15/2025	8:30:00 AM	0.61
11/15/2025	8:45:00 AM	0.6

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/15/2025	9:00:00 AM	0.6
11/15/2025	9:15:00 AM	0.6
11/15/2025	9:30:00 AM	0.6
11/15/2025	9:45:00 AM	0.6
11/15/2025	10:00:00 AM	0.6
11/15/2025	10:15:00 AM	0.6
11/15/2025	10:30:00 AM	0.59
11/15/2025	10:45:00 AM	0.59
11/15/2025	11:00:00 AM	0.59
11/15/2025	11:15:00 AM	0.59
11/15/2025	11:30:00 AM	0.58
11/15/2025	11:45:00 AM	0.58
11/15/2025	12:00:00 PM	0.58
11/15/2025	12:15:00 PM	0.58
11/15/2025	12:30:00 PM	0.58
11/15/2025	12:45:00 PM	0.58
11/15/2025	1:00:00 PM	0.58
11/15/2025	1:15:00 PM	0.58
11/15/2025	1:30:00 PM	0.57
11/15/2025	1:45:00 PM	0.57
11/15/2025	2:00:00 PM	0.57
11/15/2025	2:15:00 PM	0.57
11/15/2025	2:30:00 PM	0.57
11/15/2025	2:45:00 PM	0.57
11/15/2025	3:00:00 PM	0.57
11/15/2025	3:15:00 PM	0.57
11/15/2025	3:30:00 PM	0.57
11/15/2025	3:45:00 PM	0.57
11/15/2025	4:00:00 PM	0.58
11/15/2025	4:15:00 PM	0.58
11/15/2025	4:30:00 PM	0.59
11/15/2025	4:45:00 PM	0.6
11/15/2025	5:00:00 PM	0.6
11/15/2025	5:15:00 PM	0.61
11/15/2025	5:30:00 PM	0.61
11/15/2025	5:45:00 PM	0.61
11/15/2025	6:00:00 PM	0.61
11/15/2025	6:15:00 PM	0.61
11/15/2025	6:30:00 PM	0.61
11/15/2025	6:45:00 PM	0.61
11/15/2025	7:00:00 PM	0.61
11/15/2025	7:15:00 PM	0.61
11/15/2025	7:30:00 PM	0.61
11/15/2025	7:45:00 PM	0.61
11/15/2025	8:00:00 PM	0.61
11/15/2025	8:15:00 PM	0.61

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/15/2025	8:30:00 PM	0.6
11/15/2025	8:45:00 PM	0.6
11/15/2025	9:00:00 PM	0.6
11/15/2025	9:15:00 PM	0.6
11/15/2025	9:30:00 PM	0.61
11/15/2025	9:45:00 PM	0.61
11/15/2025	10:00:00 PM	0.61
11/15/2025	10:15:00 PM	0.61
11/15/2025	10:30:00 PM	0.61
11/15/2025	10:45:00 PM	0.61
11/15/2025	11:00:00 PM	0.61
11/15/2025	11:15:00 PM	0.61
11/15/2025	11:30:00 PM	0.6
11/15/2025	11:45:00 PM	0.6
11/16/2025	12:00:00 AM	0.6
11/16/2025	12:15:00 AM	0.6
11/16/2025	12:30:00 AM	0.6
11/16/2025	12:45:00 AM	0.6
11/16/2025	1:00:00 AM	0.6
11/16/2025	1:15:00 AM	0.6
11/16/2025	1:30:00 AM	0.59
11/16/2025	1:45:00 AM	0.59
11/16/2025	2:00:00 AM	0.59
11/16/2025	2:15:00 AM	0.59
11/16/2025	2:30:00 AM	0.59
11/16/2025	2:45:00 AM	0.59
11/16/2025	3:00:00 AM	0.59
11/16/2025	3:15:00 AM	0.59
11/16/2025	3:30:00 AM	0.59
11/16/2025	3:45:00 AM	0.58
11/16/2025	4:00:00 AM	0.58
11/16/2025	4:15:00 AM	0.58
11/16/2025	4:30:00 AM	0.58
11/16/2025	4:45:00 AM	0.58
11/16/2025	5:00:00 AM	0.58
11/16/2025	5:15:00 AM	0.58
11/16/2025	5:30:00 AM	0.58
11/16/2025	5:45:00 AM	0.58
11/16/2025	6:00:00 AM	0.58
11/16/2025	6:15:00 AM	0.58
11/16/2025	6:30:00 AM	0.58
11/16/2025	6:45:00 AM	0.58
11/16/2025	7:00:00 AM	0.57
11/16/2025	7:15:00 AM	0.57
11/16/2025	7:30:00 AM	0.57
11/16/2025	7:45:00 AM	0.57

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/16/2025	8:00:00 AM	0.57
11/16/2025	8:15:00 AM	0.57
11/16/2025	8:30:00 AM	0.57
11/16/2025	8:45:00 AM	0.57
11/16/2025	9:00:00 AM	0.57
11/16/2025	9:15:00 AM	0.57
11/16/2025	9:30:00 AM	0.57
11/16/2025	9:45:00 AM	0.57
11/16/2025	10:00:00 AM	0.57
11/16/2025	10:15:00 AM	0.57
11/16/2025	10:30:00 AM	0.57
11/16/2025	10:45:00 AM	0.57
11/16/2025	11:00:00 AM	0.57
11/16/2025	11:15:00 AM	0.58
11/16/2025	11:30:00 AM	0.59
11/16/2025	11:45:00 AM	0.61
11/16/2025	12:00:00 PM	0.63
11/16/2025	12:15:00 PM	0.65
11/16/2025	12:30:00 PM	0.67
11/16/2025	12:45:00 PM	0.7
11/16/2025	1:00:00 PM	0.73
11/16/2025	1:15:00 PM	0.74
11/16/2025	1:30:00 PM	0.76
11/16/2025	1:45:00 PM	0.78
11/16/2025	2:00:00 PM	0.8
11/16/2025	2:15:00 PM	0.82
11/16/2025	2:30:00 PM	0.83
11/16/2025	2:45:00 PM	0.84
11/16/2025	3:00:00 PM	0.85
11/16/2025	3:15:00 PM	0.85
11/16/2025	3:30:00 PM	0.85
11/16/2025	3:45:00 PM	0.85
11/16/2025	4:00:00 PM	0.85
11/16/2025	4:15:00 PM	0.85
11/16/2025	4:30:00 PM	0.85
11/16/2025	4:45:00 PM	0.84
11/16/2025	5:00:00 PM	0.84
11/16/2025	5:15:00 PM	0.83
11/16/2025	5:30:00 PM	0.83
11/16/2025	5:45:00 PM	0.82
11/16/2025	6:00:00 PM	0.81
11/16/2025	6:15:00 PM	0.8
11/16/2025	6:30:00 PM	0.8
11/16/2025	6:45:00 PM	0.79
11/16/2025	7:00:00 PM	0.78
11/16/2025	7:15:00 PM	0.78

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/16/2025	7:30:00 PM	0.77
11/16/2025	7:45:00 PM	0.76
11/16/2025	8:00:00 PM	0.76
11/16/2025	8:15:00 PM	0.75
11/16/2025	8:30:00 PM	0.74
11/16/2025	8:45:00 PM	0.74
11/16/2025	9:00:00 PM	0.73
11/16/2025	9:15:00 PM	0.73
11/16/2025	9:30:00 PM	0.72
11/16/2025	9:45:00 PM	0.72
11/16/2025	10:00:00 PM	0.71
11/16/2025	10:15:00 PM	0.7
11/16/2025	10:30:00 PM	0.7
11/16/2025	10:45:00 PM	0.69
11/16/2025	11:00:00 PM	0.69
11/16/2025	11:15:00 PM	0.68
11/16/2025	11:30:00 PM	0.68
11/16/2025	11:45:00 PM	0.67
11/17/2025	12:00:00 AM	0.67
11/17/2025	12:15:00 AM	0.66
11/17/2025	12:30:00 AM	0.66
11/17/2025	12:45:00 AM	0.65
11/17/2025	1:00:00 AM	0.65
11/17/2025	1:15:00 AM	0.65
11/17/2025	1:30:00 AM	0.64
11/17/2025	1:45:00 AM	0.64
11/17/2025	2:00:00 AM	0.64
11/17/2025	2:15:00 AM	0.63
11/17/2025	2:30:00 AM	0.63
11/17/2025	2:45:00 AM	0.62
11/17/2025	3:00:00 AM	0.62
11/17/2025	3:15:00 AM	0.62
11/17/2025	3:30:00 AM	0.62
11/17/2025	3:45:00 AM	0.61
11/17/2025	4:00:00 AM	0.61
11/17/2025	4:15:00 AM	0.61
11/17/2025	4:30:00 AM	0.61
11/17/2025	4:45:00 AM	0.6
11/17/2025	5:00:00 AM	0.6
11/17/2025	5:15:00 AM	0.6
11/17/2025	5:30:00 AM	0.6
11/17/2025	5:45:00 AM	0.6
11/17/2025	6:00:00 AM	0.59
11/17/2025	6:15:00 AM	0.59
11/17/2025	6:30:00 AM	0.59
11/17/2025	6:45:00 AM	0.59

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/17/2025	7:00:00 AM	0.59
11/17/2025	7:15:00 AM	0.59
11/17/2025	7:30:00 AM	0.58
11/17/2025	7:45:00 AM	0.58
11/17/2025	8:00:00 AM	0.58
11/17/2025	8:15:00 AM	0.58
11/17/2025	8:30:00 AM	0.58
11/17/2025	8:45:00 AM	0.58
11/17/2025	9:00:00 AM	0.58
11/17/2025	9:15:00 AM	0.58
11/17/2025	9:30:00 AM	0.57
11/17/2025	9:45:00 AM	0.57
11/17/2025	10:00:00 AM	0.57
11/17/2025	10:15:00 AM	0.57
11/17/2025	10:30:00 AM	0.57
11/17/2025	10:45:00 AM	0.57
11/17/2025	11:00:00 AM	0.57
11/17/2025	11:15:00 AM	0.57
11/17/2025	11:30:00 AM	0.57
11/17/2025	11:45:00 AM	0.57
11/17/2025	12:00:00 PM	0.57
11/17/2025	12:15:00 PM	0.56
11/17/2025	12:30:00 PM	0.56
11/17/2025	12:45:00 PM	0.56
11/17/2025	1:00:00 PM	0.56
11/17/2025	1:15:00 PM	0.56
11/17/2025	1:30:00 PM	0.56
11/17/2025	1:45:00 PM	0.56
11/17/2025	2:00:00 PM	0.56
11/17/2025	2:15:00 PM	0.56
11/17/2025	2:30:00 PM	0.56
11/17/2025	2:45:00 PM	0.55
11/17/2025	3:00:00 PM	0.55
11/17/2025	3:15:00 PM	0.55
11/17/2025	3:30:00 PM	0.56
11/17/2025	3:45:00 PM	0.56
11/17/2025	4:00:00 PM	0.56
11/17/2025	4:15:00 PM	0.55
11/17/2025	4:30:00 PM	0.55
11/17/2025	4:45:00 PM	0.55
11/17/2025	5:00:00 PM	0.55
11/17/2025	5:15:00 PM	0.55
11/17/2025	5:30:00 PM	0.55
11/17/2025	5:45:00 PM	0.55
11/17/2025	6:00:00 PM	0.55
11/17/2025	6:15:00 PM	0.54

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/17/2025	6:30:00 PM	0.54
11/17/2025	6:45:00 PM	0.54
11/17/2025	7:00:00 PM	0.54
11/17/2025	7:15:00 PM	0.54
11/17/2025	7:30:00 PM	0.54
11/17/2025	7:45:00 PM	0.54
11/17/2025	8:00:00 PM	0.54
11/17/2025	8:15:00 PM	0.54
11/17/2025	8:30:00 PM	0.54
11/17/2025	8:45:00 PM	0.54
11/17/2025	9:00:00 PM	0.54
11/17/2025	9:15:00 PM	0.55
11/17/2025	9:30:00 PM	0.55
11/17/2025	9:45:00 PM	0.55
11/17/2025	10:00:00 PM	0.55
11/17/2025	10:15:00 PM	0.56
11/17/2025	10:30:00 PM	0.56
11/17/2025	10:45:00 PM	0.56
11/17/2025	11:00:00 PM	0.56
11/17/2025	11:15:00 PM	0.56
11/17/2025	11:30:00 PM	0.56
11/17/2025	11:45:00 PM	0.56
11/18/2025	12:00:00 AM	0.56
11/18/2025	12:15:00 AM	0.56
11/18/2025	12:30:00 AM	0.57
11/18/2025	12:45:00 AM	0.56
11/18/2025	1:00:00 AM	0.56
11/18/2025	1:15:00 AM	0.56
11/18/2025	1:30:00 AM	0.56
11/18/2025	1:45:00 AM	0.56
11/18/2025	2:00:00 AM	0.56
11/18/2025	2:15:00 AM	0.56
11/18/2025	2:30:00 AM	0.56
11/18/2025	2:45:00 AM	0.56
11/18/2025	3:00:00 AM	0.56
11/18/2025	3:15:00 AM	0.55
11/18/2025	3:30:00 AM	0.55
11/18/2025	3:45:00 AM	0.55
11/18/2025	4:00:00 AM	0.55
11/18/2025	4:15:00 AM	0.55
11/18/2025	4:30:00 AM	0.55
11/18/2025	4:45:00 AM	0.55
11/18/2025	5:00:00 AM	0.55
11/18/2025	5:15:00 AM	0.55
11/18/2025	5:30:00 AM	0.55
11/18/2025	5:45:00 AM	0.55

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/18/2025	6:00:00 AM	0.55
11/18/2025	6:15:00 AM	0.55
11/18/2025	6:30:00 AM	0.55
11/18/2025	6:45:00 AM	0.55
11/18/2025	7:00:00 AM	0.55
11/18/2025	7:15:00 AM	0.54
11/18/2025	7:30:00 AM	0.54
11/18/2025	7:45:00 AM	0.54
11/18/2025	8:00:00 AM	0.54
11/18/2025	8:15:00 AM	0.54
11/18/2025	8:30:00 AM	0.54
11/18/2025	8:45:00 AM	0.54
11/18/2025	9:00:00 AM	0.54
11/18/2025	9:15:00 AM	0.54
11/18/2025	9:30:00 AM	0.54
11/18/2025	9:45:00 AM	0.54
11/18/2025	10:00:00 AM	0.54
11/18/2025	10:15:00 AM	0.54
11/18/2025	10:30:00 AM	0.54
11/18/2025	10:45:00 AM	0.54
11/18/2025	11:00:00 AM	0.54
11/18/2025	11:15:00 AM	0.54
11/18/2025	11:30:00 AM	0.54
11/18/2025	11:45:00 AM	0.54
11/18/2025	12:00:00 PM	0.54
11/18/2025	12:15:00 PM	0.54
11/18/2025	12:30:00 PM	0.54
11/18/2025	12:45:00 PM	0.54
11/18/2025	1:00:00 PM	0.54
11/18/2025	1:15:00 PM	0.54
11/18/2025	1:30:00 PM	0.54
11/18/2025	1:45:00 PM	0.54
11/18/2025	2:00:00 PM	0.54
11/18/2025	2:15:00 PM	0.54
11/18/2025	2:30:00 PM	0.54
11/18/2025	2:45:00 PM	0.54
11/18/2025	3:00:00 PM	0.54
11/18/2025	3:15:00 PM	0.54
11/18/2025	3:30:00 PM	0.54
11/18/2025	3:45:00 PM	0.54
11/18/2025	4:00:00 PM	0.54
11/18/2025	4:15:00 PM	0.54
11/18/2025	4:30:00 PM	0.54
11/18/2025	4:45:00 PM	0.54
11/18/2025	5:00:00 PM	0.54
11/18/2025	5:15:00 PM	0.54

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/18/2025	5:30:00 PM	0.54
11/18/2025	5:45:00 PM	0.54
11/18/2025	6:00:00 PM	0.54
11/18/2025	6:15:00 PM	0.54
11/18/2025	6:30:00 PM	0.54
11/18/2025	6:45:00 PM	0.53
11/18/2025	7:00:00 PM	0.53
11/18/2025	7:15:00 PM	0.53
11/18/2025	7:30:00 PM	0.53
11/18/2025	7:45:00 PM	0.53
11/18/2025	8:00:00 PM	0.53
11/18/2025	8:15:00 PM	0.53
11/18/2025	8:30:00 PM	0.53
11/18/2025	8:45:00 PM	0.53
11/18/2025	9:00:00 PM	0.53
11/18/2025	9:15:00 PM	0.53
11/18/2025	9:30:00 PM	0.53
11/18/2025	9:45:00 PM	0.53
11/18/2025	10:00:00 PM	0.53
11/18/2025	10:15:00 PM	0.53
11/18/2025	10:30:00 PM	0.53
11/18/2025	10:45:00 PM	0.53
11/18/2025	11:00:00 PM	0.53
11/18/2025	11:15:00 PM	0.53
11/18/2025	11:30:00 PM	0.53
11/18/2025	11:45:00 PM	0.53
11/19/2025	12:00:00 AM	0.53
11/19/2025	12:15:00 AM	0.53
11/19/2025	12:30:00 AM	0.53
11/19/2025	12:45:00 AM	0.53
11/19/2025	1:00:00 AM	0.53
11/19/2025	1:15:00 AM	0.53
11/19/2025	1:30:00 AM	0.53
11/19/2025	1:45:00 AM	0.53
11/19/2025	2:00:00 AM	0.53
11/19/2025	2:15:00 AM	0.53
11/19/2025	2:30:00 AM	0.53
11/19/2025	2:45:00 AM	0.53
11/19/2025	3:00:00 AM	0.53
11/19/2025	3:15:00 AM	0.53
11/19/2025	3:30:00 AM	0.53
11/19/2025	3:45:00 AM	0.53
11/19/2025	4:00:00 AM	0.53
11/19/2025	4:15:00 AM	0.53
11/19/2025	4:30:00 AM	0.53
11/19/2025	4:45:00 AM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/19/2025	5:00:00 AM	0.53
11/19/2025	5:15:00 AM	0.53
11/19/2025	5:30:00 AM	0.53
11/19/2025	5:45:00 AM	0.53
11/19/2025	6:00:00 AM	0.53
11/19/2025	6:15:00 AM	0.53
11/19/2025	6:30:00 AM	0.53
11/19/2025	6:45:00 AM	0.53
11/19/2025	7:00:00 AM	0.53
11/19/2025	7:15:00 AM	0.53
11/19/2025	7:30:00 AM	0.53
11/19/2025	7:45:00 AM	0.53
11/19/2025	8:00:00 AM	0.53
11/19/2025	8:15:00 AM	0.53
11/19/2025	8:30:00 AM	0.53
11/19/2025	8:45:00 AM	0.53
11/19/2025	9:00:00 AM	0.53
11/19/2025	9:15:00 AM	0.53
11/19/2025	9:30:00 AM	0.53
11/19/2025	9:45:00 AM	0.53
11/19/2025	10:00:00 AM	0.53
11/19/2025	10:15:00 AM	0.53
11/19/2025	10:30:00 AM	0.53
11/19/2025	10:45:00 AM	0.53
11/19/2025	11:00:00 AM	0.53
11/19/2025	11:15:00 AM	0.53
11/19/2025	11:30:00 AM	0.53
11/19/2025	11:45:00 AM	0.53
11/19/2025	12:00:00 PM	0.53
11/19/2025	12:15:00 PM	0.53
11/19/2025	12:30:00 PM	0.53
11/19/2025	12:45:00 PM	0.53
11/19/2025	1:00:00 PM	0.53
11/19/2025	1:15:00 PM	0.53
11/19/2025	1:30:00 PM	0.53
11/19/2025	1:45:00 PM	0.53
11/19/2025	2:00:00 PM	0.53
11/19/2025	2:15:00 PM	0.53
11/19/2025	2:30:00 PM	0.53
11/19/2025	2:45:00 PM	0.53
11/19/2025	3:00:00 PM	0.53
11/19/2025	3:15:00 PM	0.53
11/19/2025	3:30:00 PM	0.53
11/19/2025	3:45:00 PM	0.53
11/19/2025	4:00:00 PM	0.52
11/19/2025	4:15:00 PM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/19/2025	4:30:00 PM	0.52
11/19/2025	4:45:00 PM	0.52
11/19/2025	5:00:00 PM	0.52
11/19/2025	5:15:00 PM	0.52
11/19/2025	5:30:00 PM	0.52
11/19/2025	5:45:00 PM	0.52
11/19/2025	6:00:00 PM	0.52
11/19/2025	6:15:00 PM	0.52
11/19/2025	6:30:00 PM	0.52
11/19/2025	6:45:00 PM	0.52
11/19/2025	7:00:00 PM	0.52
11/19/2025	7:15:00 PM	0.52
11/19/2025	7:30:00 PM	0.52
11/19/2025	7:45:00 PM	0.52
11/19/2025	8:00:00 PM	0.52
11/19/2025	8:15:00 PM	0.52
11/19/2025	8:30:00 PM	0.52
11/19/2025	8:45:00 PM	0.52
11/19/2025	9:00:00 PM	0.52
11/19/2025	9:15:00 PM	0.52
11/19/2025	9:30:00 PM	0.52
11/19/2025	9:45:00 PM	0.52
11/19/2025	10:00:00 PM	0.52
11/19/2025	10:15:00 PM	0.52
11/19/2025	10:30:00 PM	0.52
11/19/2025	10:45:00 PM	0.52
11/19/2025	11:00:00 PM	0.52
11/19/2025	11:15:00 PM	0.52
11/19/2025	11:30:00 PM	0.52
11/19/2025	11:45:00 PM	0.51
11/20/2025	12:00:00 AM	0.51
11/20/2025	12:15:00 AM	0.51
11/20/2025	12:30:00 AM	0.51
11/20/2025	12:45:00 AM	0.51
11/20/2025	1:00:00 AM	0.51
11/20/2025	1:15:00 AM	0.51
11/20/2025	1:30:00 AM	0.51
11/20/2025	1:45:00 AM	0.51
11/20/2025	2:00:00 AM	0.51
11/20/2025	2:15:00 AM	0.51
11/20/2025	2:30:00 AM	0.51
11/20/2025	2:45:00 AM	0.51
11/20/2025	3:00:00 AM	0.51
11/20/2025	3:15:00 AM	0.51
11/20/2025	3:30:00 AM	0.51
11/20/2025	3:45:00 AM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/20/2025	4:00:00 AM	0.51
11/20/2025	4:15:00 AM	0.51
11/20/2025	4:30:00 AM	0.51
11/20/2025	4:45:00 AM	0.51
11/20/2025	5:00:00 AM	0.51
11/20/2025	5:15:00 AM	0.51
11/20/2025	5:30:00 AM	0.51
11/20/2025	5:45:00 AM	0.51
11/20/2025	6:00:00 AM	0.51
11/20/2025	6:15:00 AM	0.51
11/20/2025	6:30:00 AM	0.51
11/20/2025	6:45:00 AM	0.51
11/20/2025	7:00:00 AM	0.51
11/20/2025	7:15:00 AM	0.51
11/20/2025	7:30:00 AM	0.51
11/20/2025	7:45:00 AM	0.51
11/20/2025	8:00:00 AM	0.51
11/20/2025	8:15:00 AM	0.51
11/20/2025	8:30:00 AM	0.51
11/20/2025	8:45:00 AM	0.51
11/20/2025	9:00:00 AM	0.51
11/20/2025	9:15:00 AM	0.51
11/20/2025	9:30:00 AM	0.51
11/20/2025	9:45:00 AM	0.51
11/20/2025	10:00:00 AM	0.51
11/20/2025	10:15:00 AM	0.51
11/20/2025	10:30:00 AM	0.51
11/20/2025	10:45:00 AM	0.51
11/20/2025	11:00:00 AM	0.51
11/20/2025	11:15:00 AM	0.51
11/20/2025	11:30:00 AM	0.51
11/20/2025	11:45:00 AM	0.51
11/20/2025	12:00:00 PM	0.51
11/20/2025	12:15:00 PM	0.51
11/20/2025	12:30:00 PM	0.51
11/20/2025	12:45:00 PM	0.51
11/20/2025	1:00:00 PM	0.51
11/20/2025	1:15:00 PM	0.51
11/20/2025	1:30:00 PM	0.51
11/20/2025	1:45:00 PM	0.51
11/20/2025	2:00:00 PM	0.51
11/20/2025	2:15:00 PM	0.51
11/20/2025	2:30:00 PM	0.51
11/20/2025	2:45:00 PM	0.51
11/20/2025	3:00:00 PM	0.51
11/20/2025	3:15:00 PM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/20/2025	3:30:00 PM	0.51
11/20/2025	3:45:00 PM	0.51
11/20/2025	4:00:00 PM	0.51
11/20/2025	4:15:00 PM	0.51
11/20/2025	4:30:00 PM	0.51
11/20/2025	4:45:00 PM	0.51
11/20/2025	5:00:00 PM	0.51
11/20/2025	5:15:00 PM	0.51
11/20/2025	5:30:00 PM	0.51
11/20/2025	5:45:00 PM	0.51
11/20/2025	6:00:00 PM	0.51
11/20/2025	6:15:00 PM	0.51
11/20/2025	6:30:00 PM	0.51
11/20/2025	6:45:00 PM	0.51
11/20/2025	7:00:00 PM	0.51
11/20/2025	7:15:00 PM	0.51
11/20/2025	7:30:00 PM	0.51
11/20/2025	7:45:00 PM	0.51
11/20/2025	8:00:00 PM	0.51
11/20/2025	8:15:00 PM	0.51
11/20/2025	8:30:00 PM	0.51
11/20/2025	8:45:00 PM	0.51
11/20/2025	9:00:00 PM	0.51
11/20/2025	9:15:00 PM	0.51
11/20/2025	9:30:00 PM	0.51
11/20/2025	9:45:00 PM	0.51
11/20/2025	10:00:00 PM	0.51
11/20/2025	10:15:00 PM	0.51
11/20/2025	10:30:00 PM	0.51
11/20/2025	10:45:00 PM	0.51
11/20/2025	11:00:00 PM	0.51
11/20/2025	11:15:00 PM	0.51
11/20/2025	11:30:00 PM	0.51
11/20/2025	11:45:00 PM	0.51
11/21/2025	12:00:00 AM	0.51
11/21/2025	12:15:00 AM	0.51
11/21/2025	12:30:00 AM	0.51
11/21/2025	12:45:00 AM	0.51
11/21/2025	1:00:00 AM	0.51
11/21/2025	1:15:00 AM	0.51
11/21/2025	1:30:00 AM	0.51
11/21/2025	1:45:00 AM	0.51
11/21/2025	2:00:00 AM	0.51
11/21/2025	2:15:00 AM	0.5
11/21/2025	2:30:00 AM	0.5
11/21/2025	2:45:00 AM	0.5

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/21/2025	3:00:00 AM	0.5
11/21/2025	3:15:00 AM	0.5
11/21/2025	3:30:00 AM	0.5
11/21/2025	3:45:00 AM	0.5
11/21/2025	4:00:00 AM	0.5
11/21/2025	4:15:00 AM	0.5
11/21/2025	4:30:00 AM	0.5
11/21/2025	4:45:00 AM	0.5
11/21/2025	5:00:00 AM	0.5
11/21/2025	5:15:00 AM	0.5
11/21/2025	5:30:00 AM	0.5
11/21/2025	5:45:00 AM	0.5
11/21/2025	6:00:00 AM	0.5
11/21/2025	6:15:00 AM	0.5
11/21/2025	6:30:00 AM	0.5
11/21/2025	6:45:00 AM	0.5
11/21/2025	7:00:00 AM	0.5
11/21/2025	7:15:00 AM	0.5
11/21/2025	7:30:00 AM	0.5
11/21/2025	7:45:00 AM	0.5
11/21/2025	8:00:00 AM	0.5
11/21/2025	8:15:00 AM	0.5
11/21/2025	8:30:00 AM	0.5
11/21/2025	8:45:00 AM	0.5
11/21/2025	9:00:00 AM	0.5
11/21/2025	9:15:00 AM	0.5
11/21/2025	9:30:00 AM	0.5
11/21/2025	9:45:00 AM	0.5
11/21/2025	10:00:00 AM	0.5
11/21/2025	10:15:00 AM	0.5
11/21/2025	10:30:00 AM	0.5
11/21/2025	10:45:00 AM	0.5
11/21/2025	11:00:00 AM	0.5
11/21/2025	11:15:00 AM	0.5
11/21/2025	11:30:00 AM	0.5
11/21/2025	11:45:00 AM	0.5
11/21/2025	12:00:00 PM	0.5
11/21/2025	12:15:00 PM	0.5
11/21/2025	12:30:00 PM	0.5
11/21/2025	12:45:00 PM	0.5
11/21/2025	1:00:00 PM	0.5
11/21/2025	1:15:00 PM	0.5
11/21/2025	1:30:00 PM	0.5
11/21/2025	1:45:00 PM	0.5
11/21/2025	2:00:00 PM	0.5
11/21/2025	2:15:00 PM	0.5

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/21/2025	2:30:00 PM	0.5
11/21/2025	2:45:00 PM	0.5
11/21/2025	3:00:00 PM	0.5
11/21/2025	3:15:00 PM	0.5
11/21/2025	3:30:00 PM	0.5
11/21/2025	3:45:00 PM	0.5
11/21/2025	4:00:00 PM	0.5
11/21/2025	4:15:00 PM	0.5
11/21/2025	4:30:00 PM	0.5
11/21/2025	4:45:00 PM	0.5
11/21/2025	5:00:00 PM	0.5
11/21/2025	5:15:00 PM	0.5
11/21/2025	5:30:00 PM	0.5
11/21/2025	5:45:00 PM	0.5
11/21/2025	6:00:00 PM	0.5
11/21/2025	6:15:00 PM	0.5
11/21/2025	6:30:00 PM	0.5
11/21/2025	6:45:00 PM	0.5
11/21/2025	7:00:00 PM	0.5
11/21/2025	7:15:00 PM	0.5
11/21/2025	7:30:00 PM	0.5
11/21/2025	7:45:00 PM	0.5
11/21/2025	8:00:00 PM	0.5
11/21/2025	8:15:00 PM	0.5
11/21/2025	8:30:00 PM	0.5
11/21/2025	8:45:00 PM	0.5
11/21/2025	9:00:00 PM	0.5
11/21/2025	9:15:00 PM	0.5
11/21/2025	9:30:00 PM	0.5
11/21/2025	9:45:00 PM	0.5
11/21/2025	10:00:00 PM	0.5
11/21/2025	10:15:00 PM	0.5
11/21/2025	10:30:00 PM	0.5
11/21/2025	10:45:00 PM	0.5
11/21/2025	11:00:00 PM	0.5
11/21/2025	11:15:00 PM	0.5
11/21/2025	11:30:00 PM	0.5
11/21/2025	11:45:00 PM	0.5
11/22/2025	12:00:00 AM	0.5
11/22/2025	12:15:00 AM	0.5
11/22/2025	12:30:00 AM	0.5
11/22/2025	12:45:00 AM	0.5
11/22/2025	1:00:00 AM	0.5
11/22/2025	1:15:00 AM	0.5
11/22/2025	1:30:00 AM	0.5
11/22/2025	1:45:00 AM	0.5

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/22/2025	2:00:00 AM	0.5
11/22/2025	2:15:00 AM	0.5
11/22/2025	2:30:00 AM	0.5
11/22/2025	2:45:00 AM	0.5
11/22/2025	3:00:00 AM	0.5
11/22/2025	3:15:00 AM	0.5
11/22/2025	3:30:00 AM	0.5
11/22/2025	3:45:00 AM	0.5
11/22/2025	4:00:00 AM	0.5
11/22/2025	4:15:00 AM	0.5
11/22/2025	4:30:00 AM	0.5
11/22/2025	4:45:00 AM	0.5
11/22/2025	5:00:00 AM	0.5
11/22/2025	5:15:00 AM	0.5
11/22/2025	5:30:00 AM	0.5
11/22/2025	5:45:00 AM	0.5
11/22/2025	6:00:00 AM	0.5
11/22/2025	6:15:00 AM	0.5
11/22/2025	6:30:00 AM	0.5
11/22/2025	6:45:00 AM	0.5
11/22/2025	7:00:00 AM	0.5
11/22/2025	7:15:00 AM	0.5
11/22/2025	7:30:00 AM	0.5
11/22/2025	7:45:00 AM	0.5
11/22/2025	8:00:00 AM	0.5
11/22/2025	8:15:00 AM	0.5
11/22/2025	8:30:00 AM	0.5
11/22/2025	8:45:00 AM	0.5
11/22/2025	9:00:00 AM	0.5
11/22/2025	9:15:00 AM	0.5
11/22/2025	9:30:00 AM	0.5
11/22/2025	9:45:00 AM	0.5
11/22/2025	10:00:00 AM	0.5
11/22/2025	10:15:00 AM	0.5
11/22/2025	10:30:00 AM	0.5
11/22/2025	10:45:00 AM	0.5
11/22/2025	11:00:00 AM	0.5
11/22/2025	11:15:00 AM	0.5
11/22/2025	11:30:00 AM	0.5
11/22/2025	11:45:00 AM	0.5
11/22/2025	12:00:00 PM	0.5
11/22/2025	12:15:00 PM	0.5
11/22/2025	12:30:00 PM	0.5
11/22/2025	12:45:00 PM	0.5
11/22/2025	1:00:00 PM	0.5
11/22/2025	1:15:00 PM	0.5

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/22/2025	1:30:00 PM	0.5
11/22/2025	1:45:00 PM	0.5
11/22/2025	2:00:00 PM	0.5
11/22/2025	2:15:00 PM	0.5
11/22/2025	2:30:00 PM	0.5
11/22/2025	2:45:00 PM	0.5
11/22/2025	3:00:00 PM	0.5
11/22/2025	3:15:00 PM	0.5
11/22/2025	3:30:00 PM	0.51
11/22/2025	3:45:00 PM	0.5
11/22/2025	4:00:00 PM	0.5
11/22/2025	4:15:00 PM	0.5
11/22/2025	4:30:00 PM	0.51
11/22/2025	4:45:00 PM	0.51
11/22/2025	5:00:00 PM	0.51
11/22/2025	5:15:00 PM	0.51
11/22/2025	5:30:00 PM	0.51
11/22/2025	5:45:00 PM	0.51
11/22/2025	6:00:00 PM	0.51
11/22/2025	6:15:00 PM	0.51
11/22/2025	6:30:00 PM	0.51
11/22/2025	6:45:00 PM	0.51
11/22/2025	7:00:00 PM	0.51
11/22/2025	7:15:00 PM	0.51
11/22/2025	7:30:00 PM	0.51
11/22/2025	7:45:00 PM	0.51
11/22/2025	8:00:00 PM	0.51
11/22/2025	8:15:00 PM	0.51
11/22/2025	8:30:00 PM	0.51
11/22/2025	8:45:00 PM	0.51
11/22/2025	9:00:00 PM	0.51
11/22/2025	9:15:00 PM	0.51
11/22/2025	9:30:00 PM	0.51
11/22/2025	9:45:00 PM	0.51
11/22/2025	10:00:00 PM	0.51
11/22/2025	10:15:00 PM	0.51
11/22/2025	10:30:00 PM	0.51
11/22/2025	10:45:00 PM	0.51
11/22/2025	11:00:00 PM	0.51
11/22/2025	11:15:00 PM	0.51
11/22/2025	11:30:00 PM	0.51
11/22/2025	11:45:00 PM	0.51
11/23/2025	12:00:00 AM	0.51
11/23/2025	12:15:00 AM	0.51
11/23/2025	12:30:00 AM	0.51
11/23/2025	12:45:00 AM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/23/2025	1:00:00 AM	0.51
11/23/2025	1:15:00 AM	0.51
11/23/2025	1:30:00 AM	0.51
11/23/2025	1:45:00 AM	0.51
11/23/2025	2:00:00 AM	0.51
11/23/2025	2:15:00 AM	0.51
11/23/2025	2:30:00 AM	0.51
11/23/2025	2:45:00 AM	0.51
11/23/2025	3:00:00 AM	0.51
11/23/2025	3:15:00 AM	0.51
11/23/2025	3:30:00 AM	0.51
11/23/2025	3:45:00 AM	0.51
11/23/2025	4:00:00 AM	0.51
11/23/2025	4:15:00 AM	0.51
11/23/2025	4:30:00 AM	0.51
11/23/2025	4:45:00 AM	0.51
11/23/2025	5:00:00 AM	0.51
11/23/2025	5:15:00 AM	0.51
11/23/2025	5:30:00 AM	0.51
11/23/2025	5:45:00 AM	0.51
11/23/2025	6:00:00 AM	0.51
11/23/2025	6:15:00 AM	0.51
11/23/2025	6:30:00 AM	0.51
11/23/2025	6:45:00 AM	0.51
11/23/2025	7:00:00 AM	0.51
11/23/2025	7:15:00 AM	0.51
11/23/2025	7:30:00 AM	0.51
11/23/2025	7:45:00 AM	0.51
11/23/2025	8:00:00 AM	0.51
11/23/2025	8:15:00 AM	0.51
11/23/2025	8:30:00 AM	0.51
11/23/2025	8:45:00 AM	0.51
11/23/2025	9:00:00 AM	0.51
11/23/2025	9:15:00 AM	0.51
11/23/2025	9:30:00 AM	0.51
11/23/2025	9:45:00 AM	0.51
11/23/2025	10:00:00 AM	0.51
11/23/2025	10:15:00 AM	0.51
11/23/2025	10:30:00 AM	0.51
11/23/2025	10:45:00 AM	0.51
11/23/2025	11:00:00 AM	0.51
11/23/2025	11:15:00 AM	0.51
11/23/2025	11:30:00 AM	0.51
11/23/2025	11:45:00 AM	0.51
11/23/2025	12:00:00 PM	0.51
11/23/2025	12:15:00 PM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/23/2025	12:30:00 PM	0.51
11/23/2025	12:45:00 PM	0.51
11/23/2025	1:00:00 PM	0.51
11/23/2025	1:15:00 PM	0.51
11/23/2025	1:30:00 PM	0.51
11/23/2025	1:45:00 PM	0.51
11/23/2025	2:00:00 PM	0.51
11/23/2025	2:15:00 PM	0.51
11/23/2025	2:30:00 PM	0.51
11/23/2025	2:45:00 PM	0.51
11/23/2025	3:00:00 PM	0.51
11/23/2025	3:15:00 PM	0.51
11/23/2025	3:30:00 PM	0.51
11/23/2025	3:45:00 PM	0.51
11/23/2025	4:00:00 PM	0.51
11/23/2025	4:15:00 PM	0.51
11/23/2025	4:30:00 PM	0.51
11/23/2025	4:45:00 PM	0.51
11/23/2025	5:00:00 PM	0.51
11/23/2025	5:15:00 PM	0.51
11/23/2025	5:30:00 PM	0.51
11/23/2025	5:45:00 PM	0.51
11/23/2025	6:00:00 PM	0.51
11/23/2025	6:15:00 PM	0.51
11/23/2025	6:30:00 PM	0.51
11/23/2025	6:45:00 PM	0.51
11/23/2025	7:00:00 PM	0.51
11/23/2025	7:15:00 PM	0.51
11/23/2025	7:30:00 PM	0.51
11/23/2025	7:45:00 PM	0.51
11/23/2025	8:00:00 PM	0.51
11/23/2025	8:15:00 PM	0.51
11/23/2025	8:30:00 PM	0.51
11/23/2025	8:45:00 PM	0.51
11/23/2025	9:00:00 PM	0.51
11/23/2025	9:15:00 PM	0.51
11/23/2025	9:30:00 PM	0.51
11/23/2025	9:45:00 PM	0.51
11/23/2025	10:00:00 PM	0.51
11/23/2025	10:15:00 PM	0.51
11/23/2025	10:30:00 PM	0.51
11/23/2025	10:45:00 PM	0.51
11/23/2025	11:00:00 PM	0.51
11/23/2025	11:15:00 PM	0.51
11/23/2025	11:30:00 PM	0.51
11/23/2025	11:45:00 PM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/24/2025	12:00:00 AM	0.51
11/24/2025	12:15:00 AM	0.51
11/24/2025	12:30:00 AM	0.51
11/24/2025	12:45:00 AM	0.51
11/24/2025	1:00:00 AM	0.51
11/24/2025	1:15:00 AM	0.51
11/24/2025	1:30:00 AM	0.51
11/24/2025	1:45:00 AM	0.51
11/24/2025	2:00:00 AM	0.51
11/24/2025	2:15:00 AM	0.51
11/24/2025	2:30:00 AM	0.51
11/24/2025	2:45:00 AM	0.51
11/24/2025	3:00:00 AM	0.51
11/24/2025	3:15:00 AM	0.51
11/24/2025	3:30:00 AM	0.51
11/24/2025	3:45:00 AM	0.51
11/24/2025	4:00:00 AM	0.51
11/24/2025	4:15:00 AM	0.51
11/24/2025	4:30:00 AM	0.51
11/24/2025	4:45:00 AM	0.51
11/24/2025	5:00:00 AM	0.51
11/24/2025	5:15:00 AM	0.51
11/24/2025	5:30:00 AM	0.51
11/24/2025	5:45:00 AM	0.51
11/24/2025	6:00:00 AM	0.51
11/24/2025	6:15:00 AM	0.51
11/24/2025	6:30:00 AM	0.51
11/24/2025	6:45:00 AM	0.51
11/24/2025	7:00:00 AM	0.51
11/24/2025	7:15:00 AM	0.51
11/24/2025	7:30:00 AM	0.51
11/24/2025	7:45:00 AM	0.51
11/24/2025	8:00:00 AM	0.51
11/24/2025	8:15:00 AM	0.51
11/24/2025	8:30:00 AM	0.51
11/24/2025	8:45:00 AM	0.51
11/24/2025	9:00:00 AM	0.51
11/24/2025	9:15:00 AM	0.51
11/24/2025	9:30:00 AM	0.51
11/24/2025	9:45:00 AM	0.51
11/24/2025	10:00:00 AM	0.51
11/24/2025	10:15:00 AM	0.51
11/24/2025	10:30:00 AM	0.51
11/24/2025	10:45:00 AM	0.51
11/24/2025	11:00:00 AM	0.51
11/24/2025	11:15:00 AM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/24/2025	11:30:00 AM	0.51
11/24/2025	11:45:00 AM	0.51
11/24/2025	12:00:00 PM	0.51
11/24/2025	12:15:00 PM	0.51
11/24/2025	12:30:00 PM	0.51
11/24/2025	12:45:00 PM	0.51
11/24/2025	1:00:00 PM	0.51
11/24/2025	1:15:00 PM	0.51
11/24/2025	1:30:00 PM	0.51
11/24/2025	1:45:00 PM	0.51
11/24/2025	2:00:00 PM	0.51
11/24/2025	2:15:00 PM	0.51
11/24/2025	2:30:00 PM	0.51
11/24/2025	2:45:00 PM	0.51
11/24/2025	3:00:00 PM	0.51
11/24/2025	3:15:00 PM	0.51
11/24/2025	3:30:00 PM	0.51
11/24/2025	3:45:00 PM	0.51
11/24/2025	4:00:00 PM	0.51
11/24/2025	4:15:00 PM	0.51
11/24/2025	4:30:00 PM	0.51
11/24/2025	4:45:00 PM	0.51
11/24/2025	5:00:00 PM	0.51
11/24/2025	5:15:00 PM	0.51
11/24/2025	5:30:00 PM	0.51
11/24/2025	5:45:00 PM	0.51
11/24/2025	6:00:00 PM	0.51
11/24/2025	6:15:00 PM	0.51
11/24/2025	6:30:00 PM	0.51
11/24/2025	6:45:00 PM	0.51
11/24/2025	7:00:00 PM	0.51
11/24/2025	7:15:00 PM	0.51
11/24/2025	7:30:00 PM	0.51
11/24/2025	7:45:00 PM	0.51
11/24/2025	8:00:00 PM	0.51
11/24/2025	8:15:00 PM	0.51
11/24/2025	8:30:00 PM	0.51
11/24/2025	8:45:00 PM	0.51
11/24/2025	9:00:00 PM	0.51
11/24/2025	9:15:00 PM	0.51
11/24/2025	9:30:00 PM	0.51
11/24/2025	9:45:00 PM	0.51
11/24/2025	10:00:00 PM	0.51
11/24/2025	10:15:00 PM	0.51
11/24/2025	10:30:00 PM	0.51
11/24/2025	10:45:00 PM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/24/2025	11:00:00 PM	0.51
11/24/2025	11:15:00 PM	0.51
11/24/2025	11:30:00 PM	0.51
11/24/2025	11:45:00 PM	0.51
11/25/2025	12:00:00 AM	0.51
11/25/2025	12:15:00 AM	0.51
11/25/2025	12:30:00 AM	0.51
11/25/2025	12:45:00 AM	0.51
11/25/2025	1:00:00 AM	0.51
11/25/2025	1:15:00 AM	0.51
11/25/2025	1:30:00 AM	0.51
11/25/2025	1:45:00 AM	0.51
11/25/2025	2:00:00 AM	0.51
11/25/2025	2:15:00 AM	0.51
11/25/2025	2:30:00 AM	0.51
11/25/2025	2:45:00 AM	0.51
11/25/2025	3:00:00 AM	0.51
11/25/2025	3:15:00 AM	0.51
11/25/2025	3:30:00 AM	0.51
11/25/2025	3:45:00 AM	0.51
11/25/2025	4:00:00 AM	0.51
11/25/2025	4:15:00 AM	0.51
11/25/2025	4:30:00 AM	0.51
11/25/2025	4:45:00 AM	0.51
11/25/2025	5:00:00 AM	0.51
11/25/2025	5:15:00 AM	0.51
11/25/2025	5:30:00 AM	0.51
11/25/2025	5:45:00 AM	0.51
11/25/2025	6:00:00 AM	0.51
11/25/2025	6:15:00 AM	0.51
11/25/2025	6:30:00 AM	0.51
11/25/2025	6:45:00 AM	0.51
11/25/2025	7:00:00 AM	0.51
11/25/2025	7:15:00 AM	0.51
11/25/2025	7:30:00 AM	0.51
11/25/2025	7:45:00 AM	0.51
11/25/2025	8:00:00 AM	0.51
11/25/2025	8:15:00 AM	0.51
11/25/2025	8:30:00 AM	0.51
11/25/2025	8:45:00 AM	0.51
11/25/2025	9:00:00 AM	0.51
11/25/2025	9:15:00 AM	0.51
11/25/2025	9:30:00 AM	0.51
11/25/2025	9:45:00 AM	0.51
11/25/2025	10:00:00 AM	0.51
11/25/2025	10:15:00 AM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/25/2025	10:30:00 AM	0.51
11/25/2025	10:45:00 AM	0.51
11/25/2025	11:00:00 AM	0.51
11/25/2025	11:15:00 AM	0.51
11/25/2025	11:30:00 AM	0.51
11/25/2025	11:45:00 AM	0.5
11/25/2025	12:00:00 PM	0.5
11/25/2025	12:15:00 PM	0.5
11/25/2025	12:30:00 PM	0.5
11/25/2025	12:45:00 PM	0.5
11/25/2025	1:00:00 PM	0.5
11/25/2025	1:15:00 PM	0.5
11/25/2025	1:30:00 PM	0.5
11/25/2025	1:45:00 PM	0.5
11/25/2025	2:00:00 PM	0.5
11/25/2025	2:15:00 PM	0.5
11/25/2025	2:30:00 PM	0.5
11/25/2025	2:45:00 PM	0.5
11/25/2025	3:00:00 PM	0.5
11/25/2025	3:15:00 PM	0.5
11/25/2025	3:30:00 PM	0.5
11/25/2025	3:45:00 PM	0.5
11/25/2025	4:00:00 PM	0.5
11/25/2025	4:15:00 PM	0.5
11/25/2025	4:30:00 PM	0.5
11/25/2025	4:45:00 PM	0.5
11/25/2025	5:00:00 PM	0.5
11/25/2025	5:15:00 PM	0.5
11/25/2025	5:30:00 PM	0.5
11/25/2025	5:45:00 PM	0.5
11/25/2025	6:00:00 PM	0.5
11/25/2025	6:15:00 PM	0.5
11/25/2025	6:30:00 PM	0.5
11/25/2025	6:45:00 PM	0.5
11/25/2025	7:00:00 PM	0.5
11/25/2025	7:15:00 PM	0.5
11/25/2025	7:30:00 PM	0.5
11/25/2025	7:45:00 PM	0.5
11/25/2025	8:00:00 PM	0.5
11/25/2025	8:15:00 PM	0.5
11/25/2025	8:30:00 PM	0.5
11/25/2025	8:45:00 PM	0.5
11/25/2025	9:00:00 PM	0.5
11/25/2025	9:15:00 PM	0.5
11/25/2025	9:30:00 PM	0.5
11/25/2025	9:45:00 PM	0.5

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/25/2025	10:00:00 PM	0.5
11/25/2025	10:15:00 PM	0.5
11/25/2025	10:30:00 PM	0.5
11/25/2025	10:45:00 PM	0.5
11/25/2025	11:00:00 PM	0.5
11/25/2025	11:15:00 PM	0.5
11/25/2025	11:30:00 PM	0.5
11/25/2025	11:45:00 PM	0.5
11/26/2025	12:00:00 AM	0.5
11/26/2025	12:15:00 AM	0.5
11/26/2025	12:30:00 AM	0.5
11/26/2025	12:45:00 AM	0.5
11/26/2025	1:00:00 AM	0.5
11/26/2025	1:15:00 AM	0.5
11/26/2025	1:30:00 AM	0.5
11/26/2025	1:45:00 AM	0.5
11/26/2025	2:00:00 AM	0.5
11/26/2025	2:15:00 AM	0.5
11/26/2025	2:30:00 AM	0.5
11/26/2025	2:45:00 AM	0.5
11/26/2025	3:00:00 AM	0.5
11/26/2025	3:15:00 AM	0.5
11/26/2025	3:30:00 AM	0.5
11/26/2025	3:45:00 AM	0.5
11/26/2025	4:00:00 AM	0.5
11/26/2025	4:15:00 AM	0.5
11/26/2025	4:30:00 AM	0.5
11/26/2025	4:45:00 AM	0.5
11/26/2025	5:00:00 AM	0.5
11/26/2025	5:15:00 AM	0.5
11/26/2025	5:30:00 AM	0.5
11/26/2025	5:45:00 AM	0.5
11/26/2025	6:00:00 AM	0.5
11/26/2025	6:15:00 AM	0.5
11/26/2025	6:30:00 AM	0.5
11/26/2025	6:45:00 AM	0.5
11/26/2025	7:00:00 AM	0.5
11/26/2025	7:15:00 AM	0.49
11/26/2025	7:30:00 AM	0.5
11/26/2025	7:45:00 AM	0.49
11/26/2025	8:00:00 AM	0.49
11/26/2025	8:15:00 AM	0.49
11/26/2025	8:30:00 AM	0.49
11/26/2025	8:45:00 AM	0.49
11/26/2025	9:00:00 AM	0.49
11/26/2025	9:15:00 AM	0.49

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/26/2025	9:30:00 AM	0.49
11/26/2025	9:45:00 AM	0.49
11/26/2025	10:00:00 AM	0.49
11/26/2025	10:15:00 AM	0.49
11/26/2025	10:30:00 AM	0.49
11/26/2025	10:45:00 AM	0.49
11/26/2025	11:00:00 AM	0.49
11/26/2025	11:15:00 AM	0.49
11/26/2025	11:30:00 AM	0.49
11/26/2025	11:45:00 AM	0.49
11/26/2025	12:00:00 PM	0.49
11/26/2025	12:15:00 PM	0.49
11/26/2025	12:30:00 PM	0.49
11/26/2025	12:45:00 PM	0.49
11/26/2025	1:00:00 PM	0.49
11/26/2025	1:15:00 PM	0.49
11/26/2025	1:30:00 PM	0.49
11/26/2025	1:45:00 PM	0.49
11/26/2025	2:00:00 PM	0.49
11/26/2025	2:15:00 PM	0.49
11/26/2025	2:30:00 PM	0.49
11/26/2025	2:45:00 PM	0.49
11/26/2025	3:00:00 PM	0.49
11/26/2025	3:15:00 PM	0.49
11/26/2025	3:30:00 PM	0.49
11/26/2025	3:45:00 PM	0.49
11/26/2025	4:00:00 PM	0.49
11/26/2025	4:15:00 PM	0.49
11/26/2025	4:30:00 PM	0.49
11/26/2025	4:45:00 PM	0.49
11/26/2025	5:00:00 PM	0.49
11/26/2025	5:15:00 PM	0.49
11/26/2025	5:30:00 PM	0.49
11/26/2025	5:45:00 PM	0.49
11/26/2025	6:00:00 PM	0.49
11/26/2025	6:15:00 PM	0.49
11/26/2025	6:30:00 PM	0.49
11/26/2025	6:45:00 PM	0.49
11/26/2025	7:00:00 PM	0.49
11/26/2025	7:15:00 PM	0.49
11/26/2025	7:30:00 PM	0.49
11/26/2025	7:45:00 PM	0.49
11/26/2025	8:00:00 PM	0.49
11/26/2025	8:15:00 PM	0.49
11/26/2025	8:30:00 PM	0.49
11/26/2025	8:45:00 PM	0.49

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/26/2025	9:00:00 PM	0.49
11/26/2025	9:15:00 PM	0.49
11/26/2025	9:30:00 PM	0.49
11/26/2025	9:45:00 PM	0.49
11/26/2025	10:00:00 PM	0.49
11/26/2025	10:15:00 PM	0.49
11/26/2025	10:30:00 PM	0.49
11/26/2025	10:45:00 PM	0.49
11/26/2025	11:00:00 PM	0.49
11/26/2025	11:15:00 PM	0.49
11/26/2025	11:30:00 PM	0.49
11/26/2025	11:45:00 PM	0.49
11/27/2025	12:00:00 AM	0.49
11/27/2025	12:15:00 AM	0.49
11/27/2025	12:30:00 AM	0.49
11/27/2025	12:45:00 AM	0.49
11/27/2025	1:00:00 AM	0.49
11/27/2025	1:15:00 AM	0.49
11/27/2025	1:30:00 AM	0.49
11/27/2025	1:45:00 AM	0.49
11/27/2025	2:00:00 AM	0.49
11/27/2025	2:15:00 AM	0.49
11/27/2025	2:30:00 AM	0.49
11/27/2025	2:45:00 AM	0.49
11/27/2025	3:00:00 AM	0.49
11/27/2025	3:15:00 AM	0.49
11/27/2025	3:30:00 AM	0.49
11/27/2025	3:45:00 AM	0.49
11/27/2025	4:00:00 AM	0.49
11/27/2025	4:15:00 AM	0.49
11/27/2025	4:30:00 AM	0.49
11/27/2025	4:45:00 AM	0.49
11/27/2025	5:00:00 AM	0.49
11/27/2025	5:15:00 AM	0.49
11/27/2025	5:30:00 AM	0.49
11/27/2025	5:45:00 AM	0.49
11/27/2025	6:00:00 AM	0.49
11/27/2025	6:15:00 AM	0.49
11/27/2025	6:30:00 AM	0.49
11/27/2025	6:45:00 AM	0.49
11/27/2025	7:00:00 AM	0.49
11/27/2025	7:15:00 AM	0.49
11/27/2025	7:30:00 AM	0.49
11/27/2025	7:45:00 AM	0.49
11/27/2025	8:00:00 AM	0.49
11/27/2025	8:15:00 AM	0.49

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/27/2025	8:30:00 AM	0.49
11/27/2025	8:45:00 AM	0.49
11/27/2025	9:00:00 AM	0.49
11/27/2025	9:15:00 AM	0.49
11/27/2025	9:30:00 AM	0.49
11/27/2025	9:45:00 AM	0.49
11/27/2025	10:00:00 AM	0.49
11/27/2025	10:15:00 AM	0.49
11/27/2025	10:30:00 AM	0.49
11/27/2025	10:45:00 AM	0.49
11/27/2025	11:00:00 AM	0.49
11/27/2025	11:15:00 AM	0.49
11/27/2025	11:30:00 AM	0.49
11/27/2025	11:45:00 AM	0.49
11/27/2025	12:00:00 PM	0.49
11/27/2025	12:15:00 PM	0.49
11/27/2025	12:30:00 PM	0.49
11/27/2025	12:45:00 PM	0.49
11/27/2025	1:00:00 PM	0.49
11/27/2025	1:15:00 PM	0.49
11/27/2025	1:30:00 PM	0.49
11/27/2025	1:45:00 PM	0.49
11/27/2025	2:00:00 PM	0.5
11/27/2025	2:15:00 PM	0.5
11/27/2025	2:30:00 PM	0.5
11/27/2025	2:45:00 PM	0.5
11/27/2025	3:00:00 PM	0.5
11/27/2025	3:15:00 PM	0.5
11/27/2025	3:30:00 PM	0.5
11/27/2025	3:45:00 PM	0.5
11/27/2025	4:00:00 PM	0.5
11/27/2025	4:15:00 PM	0.5
11/27/2025	4:30:00 PM	0.5
11/27/2025	4:45:00 PM	0.5
11/27/2025	5:00:00 PM	0.5
11/27/2025	5:15:00 PM	0.5
11/27/2025	5:30:00 PM	0.5
11/27/2025	5:45:00 PM	0.5
11/27/2025	6:00:00 PM	0.5
11/27/2025	6:15:00 PM	0.5
11/27/2025	6:30:00 PM	0.5
11/27/2025	6:45:00 PM	0.5
11/27/2025	7:00:00 PM	0.5
11/27/2025	7:15:00 PM	0.5
11/27/2025	7:30:00 PM	0.5
11/27/2025	7:45:00 PM	0.5

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/27/2025	8:00:00 PM	0.5
11/27/2025	8:15:00 PM	0.5
11/27/2025	8:30:00 PM	0.5
11/27/2025	8:45:00 PM	0.5
11/27/2025	9:00:00 PM	0.5
11/27/2025	9:15:00 PM	0.5
11/27/2025	9:30:00 PM	0.5
11/27/2025	9:45:00 PM	0.5
11/27/2025	10:00:00 PM	0.5
11/27/2025	10:15:00 PM	0.5
11/27/2025	10:30:00 PM	0.5
11/27/2025	10:45:00 PM	0.5
11/27/2025	11:00:00 PM	0.5
11/27/2025	11:15:00 PM	0.5
11/27/2025	11:30:00 PM	0.5
11/27/2025	11:45:00 PM	0.5
11/28/2025	12:00:00 AM	0.5
11/28/2025	12:15:00 AM	0.5
11/28/2025	12:30:00 AM	0.5
11/28/2025	12:45:00 AM	0.5
11/28/2025	1:00:00 AM	0.5
11/28/2025	1:15:00 AM	0.5
11/28/2025	1:30:00 AM	0.5
11/28/2025	1:45:00 AM	0.5
11/28/2025	2:00:00 AM	0.5
11/28/2025	2:15:00 AM	0.5
11/28/2025	2:30:00 AM	0.5
11/28/2025	2:45:00 AM	0.5
11/28/2025	3:00:00 AM	0.5
11/28/2025	3:15:00 AM	0.5
11/28/2025	3:30:00 AM	0.5
11/28/2025	3:45:00 AM	0.5
11/28/2025	4:00:00 AM	0.5
11/28/2025	4:15:00 AM	0.5
11/28/2025	4:30:00 AM	0.5
11/28/2025	4:45:00 AM	0.5
11/28/2025	5:00:00 AM	0.5
11/28/2025	5:15:00 AM	0.5
11/28/2025	5:30:00 AM	0.5
11/28/2025	5:45:00 AM	0.5
11/28/2025	6:00:00 AM	0.5
11/28/2025	6:15:00 AM	0.5
11/28/2025	6:30:00 AM	0.5
11/28/2025	6:45:00 AM	0.5
11/28/2025	7:00:00 AM	0.5
11/28/2025	7:15:00 AM	0.5

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/28/2025	7:30:00 AM	0.5
11/28/2025	7:45:00 AM	0.5
11/28/2025	8:00:00 AM	0.5
11/28/2025	8:15:00 AM	0.5
11/28/2025	8:30:00 AM	0.5
11/28/2025	8:45:00 AM	0.5
11/28/2025	9:00:00 AM	0.5
11/28/2025	9:15:00 AM	0.5
11/28/2025	9:30:00 AM	0.5
11/28/2025	9:45:00 AM	0.5
11/28/2025	10:00:00 AM	0.5
11/28/2025	10:15:00 AM	0.5
11/28/2025	10:30:00 AM	0.5
11/28/2025	10:45:00 AM	0.5
11/28/2025	11:00:00 AM	0.5
11/28/2025	11:15:00 AM	0.5
11/28/2025	11:30:00 AM	0.5
11/28/2025	11:45:00 AM	0.5
11/28/2025	12:00:00 PM	0.5
11/28/2025	12:15:00 PM	0.5
11/28/2025	12:30:00 PM	0.5
11/28/2025	12:45:00 PM	0.5
11/28/2025	1:00:00 PM	0.5
11/28/2025	1:15:00 PM	0.5
11/28/2025	1:30:00 PM	0.5
11/28/2025	1:45:00 PM	0.5
11/28/2025	2:00:00 PM	0.5
11/28/2025	2:15:00 PM	0.5
11/28/2025	2:30:00 PM	0.5
11/28/2025	2:45:00 PM	0.5
11/28/2025	3:00:00 PM	0.5
11/28/2025	3:15:00 PM	0.5
11/28/2025	3:30:00 PM	0.5
11/28/2025	3:45:00 PM	0.5
11/28/2025	4:00:00 PM	0.5
11/28/2025	4:15:00 PM	0.5
11/28/2025	4:30:00 PM	0.5
11/28/2025	4:45:00 PM	0.5
11/28/2025	5:00:00 PM	0.51
11/28/2025	5:15:00 PM	0.5
11/28/2025	5:30:00 PM	0.51
11/28/2025	5:45:00 PM	0.51
11/28/2025	6:00:00 PM	0.51
11/28/2025	6:15:00 PM	0.51
11/28/2025	6:30:00 PM	0.51
11/28/2025	6:45:00 PM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/28/2025	7:00:00 PM	0.51
11/28/2025	7:15:00 PM	0.51
11/28/2025	7:30:00 PM	0.51
11/28/2025	7:45:00 PM	0.51
11/28/2025	8:00:00 PM	0.51
11/28/2025	8:15:00 PM	0.51
11/28/2025	8:30:00 PM	0.51
11/28/2025	8:45:00 PM	0.51
11/28/2025	9:00:00 PM	0.51
11/28/2025	9:15:00 PM	0.51
11/28/2025	9:30:00 PM	0.51
11/28/2025	9:45:00 PM	0.51
11/28/2025	10:00:00 PM	0.51
11/28/2025	10:15:00 PM	0.51
11/28/2025	10:30:00 PM	0.51
11/28/2025	10:45:00 PM	0.51
11/28/2025	11:00:00 PM	0.51
11/28/2025	11:15:00 PM	0.51
11/28/2025	11:30:00 PM	0.51
11/28/2025	11:45:00 PM	0.51
11/29/2025	12:00:00 AM	0.51
11/29/2025	12:15:00 AM	0.51
11/29/2025	12:30:00 AM	0.51
11/29/2025	12:45:00 AM	0.51
11/29/2025	1:00:00 AM	0.51
11/29/2025	1:15:00 AM	0.51
11/29/2025	1:30:00 AM	0.51
11/29/2025	1:45:00 AM	0.51
11/29/2025	2:00:00 AM	0.51
11/29/2025	2:15:00 AM	0.51
11/29/2025	2:30:00 AM	0.51
11/29/2025	2:45:00 AM	0.51
11/29/2025	3:00:00 AM	0.51
11/29/2025	3:15:00 AM	0.51
11/29/2025	3:30:00 AM	0.51
11/29/2025	3:45:00 AM	0.51
11/29/2025	4:00:00 AM	0.51
11/29/2025	4:15:00 AM	0.51
11/29/2025	4:30:00 AM	0.51
11/29/2025	4:45:00 AM	0.51
11/29/2025	5:00:00 AM	0.51
11/29/2025	5:15:00 AM	0.51
11/29/2025	5:30:00 AM	0.51
11/29/2025	5:45:00 AM	0.51
11/29/2025	6:00:00 AM	0.51
11/29/2025	6:15:00 AM	0.51

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/29/2025	6:30:00 AM	0.51
11/29/2025	6:45:00 AM	0.51
11/29/2025	7:00:00 AM	0.51
11/29/2025	7:15:00 AM	0.52
11/29/2025	7:30:00 AM	0.52
11/29/2025	7:45:00 AM	0.52
11/29/2025	8:00:00 AM	0.52
11/29/2025	8:15:00 AM	0.52
11/29/2025	8:30:00 AM	0.52
11/29/2025	8:45:00 AM	0.52
11/29/2025	9:00:00 AM	0.52
11/29/2025	9:15:00 AM	0.52
11/29/2025	9:30:00 AM	0.52
11/29/2025	9:45:00 AM	0.52
11/29/2025	10:00:00 AM	0.52
11/29/2025	10:15:00 AM	0.52
11/29/2025	10:30:00 AM	0.52
11/29/2025	10:45:00 AM	0.52
11/29/2025	11:00:00 AM	0.52
11/29/2025	11:15:00 AM	0.52
11/29/2025	11:30:00 AM	0.52
11/29/2025	11:45:00 AM	0.52
11/29/2025	12:00:00 PM	0.52
11/29/2025	12:15:00 PM	0.52
11/29/2025	12:30:00 PM	0.52
11/29/2025	12:45:00 PM	0.52
11/29/2025	1:00:00 PM	0.52
11/29/2025	1:15:00 PM	0.52
11/29/2025	1:30:00 PM	0.52
11/29/2025	1:45:00 PM	0.52
11/29/2025	2:00:00 PM	0.52
11/29/2025	2:15:00 PM	0.52
11/29/2025	2:30:00 PM	0.52
11/29/2025	2:45:00 PM	0.52
11/29/2025	3:00:00 PM	0.52
11/29/2025	3:15:00 PM	0.52
11/29/2025	3:30:00 PM	0.52
11/29/2025	3:45:00 PM	0.52
11/29/2025	4:00:00 PM	0.52
11/29/2025	4:15:00 PM	0.52
11/29/2025	4:30:00 PM	0.52
11/29/2025	4:45:00 PM	0.52
11/29/2025	5:00:00 PM	0.52
11/29/2025	5:15:00 PM	0.52
11/29/2025	5:30:00 PM	0.52
11/29/2025	5:45:00 PM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/29/2025	6:00:00 PM	0.52
11/29/2025	6:15:00 PM	0.52
11/29/2025	6:30:00 PM	0.52
11/29/2025	6:45:00 PM	0.52
11/29/2025	7:00:00 PM	0.52
11/29/2025	7:15:00 PM	0.52
11/29/2025	7:30:00 PM	0.52
11/29/2025	7:45:00 PM	0.52
11/29/2025	8:00:00 PM	0.52
11/29/2025	8:15:00 PM	0.52
11/29/2025	8:30:00 PM	0.52
11/29/2025	8:45:00 PM	0.52
11/29/2025	9:00:00 PM	0.52
11/29/2025	9:15:00 PM	0.52
11/29/2025	9:30:00 PM	0.52
11/29/2025	9:45:00 PM	0.52
11/29/2025	10:00:00 PM	0.52
11/29/2025	10:15:00 PM	0.52
11/29/2025	10:30:00 PM	0.52
11/29/2025	10:45:00 PM	0.52
11/29/2025	11:00:00 PM	0.52
11/29/2025	11:15:00 PM	0.52
11/29/2025	11:30:00 PM	0.52
11/29/2025	11:45:00 PM	0.52
11/30/2025	12:00:00 AM	0.52
11/30/2025	12:15:00 AM	0.52
11/30/2025	12:30:00 AM	0.52
11/30/2025	12:45:00 AM	0.52
11/30/2025	1:00:00 AM	0.52
11/30/2025	1:15:00 AM	0.52
11/30/2025	1:30:00 AM	0.52
11/30/2025	1:45:00 AM	0.52
11/30/2025	2:00:00 AM	0.52
11/30/2025	2:15:00 AM	0.52
11/30/2025	2:30:00 AM	0.52
11/30/2025	2:45:00 AM	0.52
11/30/2025	3:00:00 AM	0.52
11/30/2025	3:15:00 AM	0.52
11/30/2025	3:30:00 AM	0.52
11/30/2025	3:45:00 AM	0.52
11/30/2025	4:00:00 AM	0.52
11/30/2025	4:15:00 AM	0.52
11/30/2025	4:30:00 AM	0.52
11/30/2025	4:45:00 AM	0.52
11/30/2025	5:00:00 AM	0.52
11/30/2025	5:15:00 AM	0.52

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/30/2025	5:30:00 AM	0.52
11/30/2025	5:45:00 AM	0.52
11/30/2025	6:00:00 AM	0.52
11/30/2025	6:15:00 AM	0.52
11/30/2025	6:30:00 AM	0.52
11/30/2025	6:45:00 AM	0.52
11/30/2025	7:00:00 AM	0.52
11/30/2025	7:15:00 AM	0.52
11/30/2025	7:30:00 AM	0.52
11/30/2025	7:45:00 AM	0.52
11/30/2025	8:00:00 AM	0.52
11/30/2025	8:15:00 AM	0.52
11/30/2025	8:30:00 AM	0.52
11/30/2025	8:45:00 AM	0.52
11/30/2025	9:00:00 AM	0.53
11/30/2025	9:15:00 AM	0.52
11/30/2025	9:30:00 AM	0.52
11/30/2025	9:45:00 AM	0.52
11/30/2025	10:00:00 AM	0.52
11/30/2025	10:15:00 AM	0.52
11/30/2025	10:30:00 AM	0.52
11/30/2025	10:45:00 AM	0.52
11/30/2025	11:00:00 AM	0.53
11/30/2025	11:15:00 AM	0.53
11/30/2025	11:30:00 AM	0.52
11/30/2025	11:45:00 AM	0.52
11/30/2025	12:00:00 PM	0.52
11/30/2025	12:15:00 PM	0.52
11/30/2025	12:30:00 PM	0.53
11/30/2025	12:45:00 PM	0.53
11/30/2025	1:00:00 PM	0.52
11/30/2025	1:15:00 PM	0.52
11/30/2025	1:30:00 PM	0.53
11/30/2025	1:45:00 PM	0.53
11/30/2025	2:00:00 PM	0.53
11/30/2025	2:15:00 PM	0.52
11/30/2025	2:30:00 PM	0.53
11/30/2025	2:45:00 PM	0.53
11/30/2025	3:00:00 PM	0.53
11/30/2025	3:15:00 PM	0.53
11/30/2025	3:30:00 PM	0.53
11/30/2025	3:45:00 PM	0.53
11/30/2025	4:00:00 PM	0.53
11/30/2025	4:15:00 PM	0.53
11/30/2025	4:30:00 PM	0.53
11/30/2025	4:45:00 PM	0.53

Blackrock Return Ditch Gage

DATE	TIME	GAGE
11/30/2025	5:00:00 PM	0.53
11/30/2025	5:15:00 PM	0.53
11/30/2025	5:30:00 PM	0.53
11/30/2025	5:45:00 PM	0.53
11/30/2025	6:00:00 PM	0.53
11/30/2025	6:15:00 PM	0.53
11/30/2025	6:30:00 PM	0.53
11/30/2025	6:45:00 PM	0.53
11/30/2025	7:00:00 PM	0.53
11/30/2025	7:15:00 PM	0.53
11/30/2025	7:30:00 PM	0.53
11/30/2025	7:45:00 PM	0.53
11/30/2025	8:00:00 PM	0.53
11/30/2025	8:15:00 PM	0.53
11/30/2025	8:30:00 PM	0.53
11/30/2025	8:45:00 PM	0.53
11/30/2025	9:00:00 PM	0.53
11/30/2025	9:15:00 PM	0.53
11/30/2025	9:30:00 PM	0.53
11/30/2025	9:45:00 PM	0.53
11/30/2025	10:00:00 PM	0.53
11/30/2025	10:15:00 PM	0.52
11/30/2025	10:30:00 PM	0.52
11/30/2025	10:45:00 PM	0.53
11/30/2025	11:00:00 PM	0.52
11/30/2025	11:15:00 PM	0.52
11/30/2025	11:30:00 PM	0.52
11/30/2025	11:45:00 PM	0.52

Billy Lake Return
Station 0213

Date	Flow (cfs)
11/1/2025	1.24
11/2/2025	1.24
11/3/2025	1.24
11/4/2025	1.24
11/5/2025	1.23
11/6/2025	1.17
11/7/2025	1.17
11/8/2025	1.19
11/9/2025	1.18
11/10/2025	1.09
11/11/2025	1.24
11/12/2025	1.24
11/13/2025	1.13
11/14/2025	1.19
11/15/2025	1.38
11/16/2025	1.44
11/17/2025	1.44
11/18/2025	1.50
11/19/2025	1.50
11/20/2025	1.53
11/21/2025	1.56
11/22/2025	1.50
11/23/2025	1.50
11/24/2025	1.48
11/25/2025	1.44
11/26/2025	1.49
11/27/2025	1.50
11/28/2025	1.50
11/29/2025	1.54
11/30/2025	1.50

Billy Lake Return Gage

DATE	TIME	GAGE
11/1/2025	12:00:00 AM	0.3
11/1/2025	12:15:00 AM	0.3
11/1/2025	12:30:00 AM	0.3
11/1/2025	12:45:00 AM	0.3
11/1/2025	1:00:00 AM	0.3
11/1/2025	1:15:00 AM	0.3
11/1/2025	1:30:00 AM	0.3
11/1/2025	1:45:00 AM	0.3
11/1/2025	2:00:00 AM	0.3
11/1/2025	2:15:00 AM	0.3
11/1/2025	2:30:00 AM	0.3
11/1/2025	2:45:00 AM	0.3
11/1/2025	3:00:00 AM	0.3
11/1/2025	3:15:00 AM	0.3
11/1/2025	3:30:00 AM	0.3
11/1/2025	3:45:00 AM	0.3
11/1/2025	4:00:00 AM	0.3
11/1/2025	4:15:00 AM	0.3
11/1/2025	4:30:00 AM	0.3
11/1/2025	4:45:00 AM	0.3
11/1/2025	5:00:00 AM	0.3
11/1/2025	5:15:00 AM	0.3
11/1/2025	5:30:00 AM	0.3
11/1/2025	5:45:00 AM	0.3
11/1/2025	6:00:00 AM	0.3
11/1/2025	6:15:00 AM	0.3
11/1/2025	6:30:00 AM	0.3
11/1/2025	6:45:00 AM	0.3
11/1/2025	7:00:00 AM	0.3
11/1/2025	7:15:00 AM	0.3
11/1/2025	7:30:00 AM	0.3
11/1/2025	7:45:00 AM	0.3
11/1/2025	8:00:00 AM	0.3
11/1/2025	8:15:00 AM	0.3
11/1/2025	8:30:00 AM	0.3
11/1/2025	8:45:00 AM	0.3
11/1/2025	9:00:00 AM	0.3
11/1/2025	9:15:00 AM	0.3
11/1/2025	9:30:00 AM	0.3
11/1/2025	9:45:00 AM	0.3
11/1/2025	10:00:00 AM	0.3
11/1/2025	10:15:00 AM	0.3
11/1/2025	10:30:00 AM	0.3
11/1/2025	10:45:00 AM	0.3
11/1/2025	11:00:00 AM	0.3
11/1/2025	11:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/1/2025	11:30:00 AM	0.3
11/1/2025	11:45:00 AM	0.3
11/1/2025	12:00:00 PM	0.3
11/1/2025	12:15:00 PM	0.3
11/1/2025	12:30:00 PM	0.3
11/1/2025	12:45:00 PM	0.3
11/1/2025	1:00:00 PM	0.3
11/1/2025	1:15:00 PM	0.3
11/1/2025	1:30:00 PM	0.3
11/1/2025	1:45:00 PM	0.3
11/1/2025	2:00:00 PM	0.3
11/1/2025	2:15:00 PM	0.3
11/1/2025	2:30:00 PM	0.3
11/1/2025	2:45:00 PM	0.3
11/1/2025	3:00:00 PM	0.3
11/1/2025	3:15:00 PM	0.3
11/1/2025	3:30:00 PM	0.3
11/1/2025	3:45:00 PM	0.3
11/1/2025	4:00:00 PM	0.3
11/1/2025	4:15:00 PM	0.3
11/1/2025	4:30:00 PM	0.3
11/1/2025	4:45:00 PM	0.3
11/1/2025	5:00:00 PM	0.3
11/1/2025	5:15:00 PM	0.3
11/1/2025	5:30:00 PM	0.3
11/1/2025	5:45:00 PM	0.3
11/1/2025	6:00:00 PM	0.3
11/1/2025	6:15:00 PM	0.3
11/1/2025	6:30:00 PM	0.3
11/1/2025	6:45:00 PM	0.3
11/1/2025	7:00:00 PM	0.3
11/1/2025	7:15:00 PM	0.3
11/1/2025	7:30:00 PM	0.3
11/1/2025	7:45:00 PM	0.3
11/1/2025	8:00:00 PM	0.3
11/1/2025	8:15:00 PM	0.3
11/1/2025	8:30:00 PM	0.3
11/1/2025	8:45:00 PM	0.3
11/1/2025	9:00:00 PM	0.3
11/1/2025	9:15:00 PM	0.3
11/1/2025	9:30:00 PM	0.3
11/1/2025	9:45:00 PM	0.3
11/1/2025	10:00:00 PM	0.3
11/1/2025	10:15:00 PM	0.3
11/1/2025	10:30:00 PM	0.3
11/1/2025	10:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/1/2025	11:00:00 PM	0.3
11/1/2025	11:15:00 PM	0.3
11/1/2025	11:30:00 PM	0.3
11/1/2025	11:45:00 PM	0.3
11/2/2025	12:00:00 AM	0.3
11/2/2025	12:15:00 AM	0.3
11/2/2025	12:30:00 AM	0.3
11/2/2025	12:45:00 AM	0.3
11/2/2025	1:00:00 AM	0.3
11/2/2025	1:15:00 AM	0.3
11/2/2025	1:30:00 AM	0.3
11/2/2025	1:45:00 AM	0.3
11/2/2025	2:00:00 AM	0.3
11/2/2025	2:15:00 AM	0.3
11/2/2025	2:30:00 AM	0.3
11/2/2025	2:45:00 AM	0.3
11/2/2025	3:00:00 AM	0.3
11/2/2025	3:15:00 AM	0.3
11/2/2025	3:30:00 AM	0.3
11/2/2025	3:45:00 AM	0.3
11/2/2025	4:00:00 AM	0.3
11/2/2025	4:15:00 AM	0.3
11/2/2025	4:30:00 AM	0.3
11/2/2025	4:45:00 AM	0.3
11/2/2025	5:00:00 AM	0.3
11/2/2025	5:15:00 AM	0.3
11/2/2025	5:30:00 AM	0.3
11/2/2025	5:45:00 AM	0.3
11/2/2025	6:00:00 AM	0.3
11/2/2025	6:15:00 AM	0.3
11/2/2025	6:30:00 AM	0.3
11/2/2025	6:45:00 AM	0.3
11/2/2025	7:00:00 AM	0.3
11/2/2025	7:15:00 AM	0.3
11/2/2025	7:30:00 AM	0.3
11/2/2025	7:45:00 AM	0.3
11/2/2025	8:00:00 AM	0.3
11/2/2025	8:15:00 AM	0.3
11/2/2025	8:30:00 AM	0.3
11/2/2025	8:45:00 AM	0.3
11/2/2025	9:00:00 AM	0.3
11/2/2025	9:15:00 AM	0.3
11/2/2025	9:30:00 AM	0.3
11/2/2025	9:45:00 AM	0.3
11/2/2025	10:00:00 AM	0.3
11/2/2025	10:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/2/2025	10:30:00 AM	0.3
11/2/2025	10:45:00 AM	0.3
11/2/2025	11:00:00 AM	0.3
11/2/2025	11:15:00 AM	0.3
11/2/2025	11:30:00 AM	0.3
11/2/2025	11:45:00 AM	0.3
11/2/2025	12:00:00 PM	0.3
11/2/2025	12:15:00 PM	0.3
11/2/2025	12:30:00 PM	0.3
11/2/2025	12:45:00 PM	0.3
11/2/2025	1:00:00 PM	0.3
11/2/2025	1:15:00 PM	0.3
11/2/2025	1:30:00 PM	0.3
11/2/2025	1:45:00 PM	0.3
11/2/2025	2:00:00 PM	0.3
11/2/2025	2:15:00 PM	0.3
11/2/2025	2:30:00 PM	0.3
11/2/2025	2:45:00 PM	0.3
11/2/2025	3:00:00 PM	0.3
11/2/2025	3:15:00 PM	0.3
11/2/2025	3:30:00 PM	0.3
11/2/2025	3:45:00 PM	0.3
11/2/2025	4:00:00 PM	0.3
11/2/2025	4:15:00 PM	0.3
11/2/2025	4:30:00 PM	0.3
11/2/2025	4:45:00 PM	0.3
11/2/2025	5:00:00 PM	0.3
11/2/2025	5:15:00 PM	0.3
11/2/2025	5:30:00 PM	0.3
11/2/2025	5:45:00 PM	0.3
11/2/2025	6:00:00 PM	0.3
11/2/2025	6:15:00 PM	0.3
11/2/2025	6:30:00 PM	0.3
11/2/2025	6:45:00 PM	0.3
11/2/2025	7:00:00 PM	0.3
11/2/2025	7:15:00 PM	0.3
11/2/2025	7:30:00 PM	0.3
11/2/2025	7:45:00 PM	0.3
11/2/2025	8:00:00 PM	0.3
11/2/2025	8:15:00 PM	0.3
11/2/2025	8:30:00 PM	0.3
11/2/2025	8:45:00 PM	0.3
11/2/2025	9:00:00 PM	0.3
11/2/2025	9:15:00 PM	0.3
11/2/2025	9:30:00 PM	0.3
11/2/2025	9:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/2/2025	10:00:00 PM	0.3
11/2/2025	10:15:00 PM	0.3
11/2/2025	10:30:00 PM	0.3
11/2/2025	10:45:00 PM	0.3
11/2/2025	11:00:00 PM	0.3
11/2/2025	11:15:00 PM	0.3
11/2/2025	11:30:00 PM	0.3
11/2/2025	11:45:00 PM	0.3
11/3/2025	12:00:00 AM	0.3
11/3/2025	12:15:00 AM	0.3
11/3/2025	12:30:00 AM	0.3
11/3/2025	12:45:00 AM	0.3
11/3/2025	1:00:00 AM	0.3
11/3/2025	1:15:00 AM	0.3
11/3/2025	1:30:00 AM	0.3
11/3/2025	1:45:00 AM	0.3
11/3/2025	2:00:00 AM	0.3
11/3/2025	2:15:00 AM	0.3
11/3/2025	2:30:00 AM	0.3
11/3/2025	2:45:00 AM	0.3
11/3/2025	3:00:00 AM	0.3
11/3/2025	3:15:00 AM	0.3
11/3/2025	3:30:00 AM	0.3
11/3/2025	3:45:00 AM	0.3
11/3/2025	4:00:00 AM	0.3
11/3/2025	4:15:00 AM	0.3
11/3/2025	4:30:00 AM	0.3
11/3/2025	4:45:00 AM	0.3
11/3/2025	5:00:00 AM	0.3
11/3/2025	5:15:00 AM	0.3
11/3/2025	5:30:00 AM	0.3
11/3/2025	5:45:00 AM	0.3
11/3/2025	6:00:00 AM	0.3
11/3/2025	6:15:00 AM	0.3
11/3/2025	6:30:00 AM	0.3
11/3/2025	6:45:00 AM	0.3
11/3/2025	7:00:00 AM	0.3
11/3/2025	7:15:00 AM	0.3
11/3/2025	7:30:00 AM	0.3
11/3/2025	7:45:00 AM	0.3
11/3/2025	8:00:00 AM	0.3
11/3/2025	8:15:00 AM	0.3
11/3/2025	8:30:00 AM	0.3
11/3/2025	8:45:00 AM	0.3
11/3/2025	9:00:00 AM	0.3
11/3/2025	9:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/3/2025	9:30:00 AM	0.3
11/3/2025	9:45:00 AM	0.3
11/3/2025	10:00:00 AM	0.3
11/3/2025	10:15:00 AM	0.3
11/3/2025	10:30:00 AM	0.3
11/3/2025	10:45:00 AM	0.3
11/3/2025	11:00:00 AM	0.3
11/3/2025	11:15:00 AM	0.3
11/3/2025	11:30:00 AM	0.3
11/3/2025	11:45:00 AM	0.3
11/3/2025	12:00:00 PM	0.3
11/3/2025	12:15:00 PM	0.3
11/3/2025	12:30:00 PM	0.3
11/3/2025	12:45:00 PM	0.3
11/3/2025	1:00:00 PM	0.3
11/3/2025	1:15:00 PM	0.3
11/3/2025	1:30:00 PM	0.3
11/3/2025	1:45:00 PM	0.3
11/3/2025	2:00:00 PM	0.3
11/3/2025	2:15:00 PM	0.3
11/3/2025	2:30:00 PM	0.3
11/3/2025	2:45:00 PM	0.3
11/3/2025	3:00:00 PM	0.3
11/3/2025	3:15:00 PM	0.3
11/3/2025	3:30:00 PM	0.3
11/3/2025	3:45:00 PM	0.3
11/3/2025	4:00:00 PM	0.3
11/3/2025	4:15:00 PM	0.3
11/3/2025	4:30:00 PM	0.3
11/3/2025	4:45:00 PM	0.3
11/3/2025	5:00:00 PM	0.3
11/3/2025	5:15:00 PM	0.3
11/3/2025	5:30:00 PM	0.3
11/3/2025	5:45:00 PM	0.3
11/3/2025	6:00:00 PM	0.3
11/3/2025	6:15:00 PM	0.3
11/3/2025	6:30:00 PM	0.3
11/3/2025	6:45:00 PM	0.3
11/3/2025	7:00:00 PM	0.3
11/3/2025	7:15:00 PM	0.3
11/3/2025	7:30:00 PM	0.3
11/3/2025	7:45:00 PM	0.3
11/3/2025	8:00:00 PM	0.3
11/3/2025	8:15:00 PM	0.3
11/3/2025	8:30:00 PM	0.3
11/3/2025	8:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/3/2025	9:00:00 PM	0.3
11/3/2025	9:15:00 PM	0.3
11/3/2025	9:30:00 PM	0.3
11/3/2025	9:45:00 PM	0.3
11/3/2025	10:00:00 PM	0.3
11/3/2025	10:15:00 PM	0.3
11/3/2025	10:30:00 PM	0.3
11/3/2025	10:45:00 PM	0.3
11/3/2025	11:00:00 PM	0.3
11/3/2025	11:15:00 PM	0.3
11/3/2025	11:30:00 PM	0.3
11/3/2025	11:45:00 PM	0.3
11/4/2025	12:00:00 AM	0.3
11/4/2025	12:15:00 AM	0.3
11/4/2025	12:30:00 AM	0.3
11/4/2025	12:45:00 AM	0.3
11/4/2025	1:00:00 AM	0.3
11/4/2025	1:15:00 AM	0.3
11/4/2025	1:30:00 AM	0.3
11/4/2025	1:45:00 AM	0.3
11/4/2025	2:00:00 AM	0.3
11/4/2025	2:15:00 AM	0.3
11/4/2025	2:30:00 AM	0.3
11/4/2025	2:45:00 AM	0.3
11/4/2025	3:00:00 AM	0.3
11/4/2025	3:15:00 AM	0.3
11/4/2025	3:30:00 AM	0.3
11/4/2025	3:45:00 AM	0.3
11/4/2025	4:00:00 AM	0.3
11/4/2025	4:15:00 AM	0.3
11/4/2025	4:30:00 AM	0.3
11/4/2025	4:45:00 AM	0.3
11/4/2025	5:00:00 AM	0.3
11/4/2025	5:15:00 AM	0.3
11/4/2025	5:30:00 AM	0.3
11/4/2025	5:45:00 AM	0.3
11/4/2025	6:00:00 AM	0.3
11/4/2025	6:15:00 AM	0.3
11/4/2025	6:30:00 AM	0.3
11/4/2025	6:45:00 AM	0.3
11/4/2025	7:00:00 AM	0.3
11/4/2025	7:15:00 AM	0.3
11/4/2025	7:30:00 AM	0.3
11/4/2025	7:45:00 AM	0.3
11/4/2025	8:00:00 AM	0.3
11/4/2025	8:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/4/2025	8:30:00 AM	0.3
11/4/2025	8:45:00 AM	0.3
11/4/2025	9:00:00 AM	0.3
11/4/2025	9:15:00 AM	0.3
11/4/2025	9:30:00 AM	0.3
11/4/2025	9:45:00 AM	0.3
11/4/2025	10:00:00 AM	0.3
11/4/2025	10:15:00 AM	0.3
11/4/2025	10:30:00 AM	0.3
11/4/2025	10:45:00 AM	0.3
11/4/2025	11:00:00 AM	0.3
11/4/2025	11:15:00 AM	0.3
11/4/2025	11:30:00 AM	0.3
11/4/2025	11:45:00 AM	0.3
11/4/2025	12:00:00 PM	0.3
11/4/2025	12:15:00 PM	0.3
11/4/2025	12:30:00 PM	0.3
11/4/2025	12:45:00 PM	0.3
11/4/2025	1:00:00 PM	0.3
11/4/2025	1:15:00 PM	0.3
11/4/2025	1:30:00 PM	0.3
11/4/2025	1:45:00 PM	0.3
11/4/2025	2:00:00 PM	0.3
11/4/2025	2:15:00 PM	0.3
11/4/2025	2:30:00 PM	0.3
11/4/2025	2:45:00 PM	0.3
11/4/2025	3:00:00 PM	0.3
11/4/2025	3:15:00 PM	0.3
11/4/2025	3:30:00 PM	0.3
11/4/2025	3:45:00 PM	0.3
11/4/2025	4:00:00 PM	0.3
11/4/2025	4:15:00 PM	0.3
11/4/2025	4:30:00 PM	0.3
11/4/2025	4:45:00 PM	0.3
11/4/2025	5:00:00 PM	0.3
11/4/2025	5:15:00 PM	0.3
11/4/2025	5:30:00 PM	0.3
11/4/2025	5:45:00 PM	0.3
11/4/2025	6:00:00 PM	0.3
11/4/2025	6:15:00 PM	0.3
11/4/2025	6:30:00 PM	0.3
11/4/2025	6:45:00 PM	0.3
11/4/2025	7:00:00 PM	0.3
11/4/2025	7:15:00 PM	0.3
11/4/2025	7:30:00 PM	0.3
11/4/2025	7:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/4/2025	8:00:00 PM	0.3
11/4/2025	8:15:00 PM	0.3
11/4/2025	8:30:00 PM	0.3
11/4/2025	8:45:00 PM	0.3
11/4/2025	9:00:00 PM	0.3
11/4/2025	9:15:00 PM	0.3
11/4/2025	9:30:00 PM	0.3
11/4/2025	9:45:00 PM	0.3
11/4/2025	10:00:00 PM	0.3
11/4/2025	10:15:00 PM	0.3
11/4/2025	10:30:00 PM	0.3
11/4/2025	10:45:00 PM	0.3
11/4/2025	11:00:00 PM	0.3
11/4/2025	11:15:00 PM	0.3
11/4/2025	11:30:00 PM	0.3
11/4/2025	11:45:00 PM	0.3
11/5/2025	12:00:00 AM	0.3
11/5/2025	12:15:00 AM	0.3
11/5/2025	12:30:00 AM	0.3
11/5/2025	12:45:00 AM	0.3
11/5/2025	1:00:00 AM	0.3
11/5/2025	1:15:00 AM	0.3
11/5/2025	1:30:00 AM	0.3
11/5/2025	1:45:00 AM	0.3
11/5/2025	2:00:00 AM	0.3
11/5/2025	2:15:00 AM	0.3
11/5/2025	2:30:00 AM	0.3
11/5/2025	2:45:00 AM	0.3
11/5/2025	3:00:00 AM	0.3
11/5/2025	3:15:00 AM	0.3
11/5/2025	3:30:00 AM	0.3
11/5/2025	3:45:00 AM	0.3
11/5/2025	4:00:00 AM	0.3
11/5/2025	4:15:00 AM	0.3
11/5/2025	4:30:00 AM	0.3
11/5/2025	4:45:00 AM	0.3
11/5/2025	5:00:00 AM	0.3
11/5/2025	5:15:00 AM	0.3
11/5/2025	5:30:00 AM	0.3
11/5/2025	5:45:00 AM	0.3
11/5/2025	6:00:00 AM	0.3
11/5/2025	6:15:00 AM	0.3
11/5/2025	6:30:00 AM	0.3
11/5/2025	6:45:00 AM	0.3
11/5/2025	7:00:00 AM	0.31
11/5/2025	7:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/5/2025	7:30:00 AM	0.3
11/5/2025	7:45:00 AM	0.3
11/5/2025	8:00:00 AM	0.3
11/5/2025	8:15:00 AM	0.3
11/5/2025	8:30:00 AM	0.3
11/5/2025	8:45:00 AM	0.3
11/5/2025	9:00:00 AM	0.3
11/5/2025	9:15:00 AM	0.3
11/5/2025	9:30:00 AM	0.3
11/5/2025	9:45:00 AM	0.3
11/5/2025	10:00:00 AM	0.3
11/5/2025	10:15:00 AM	0.31
11/5/2025	10:30:00 AM	0.3
11/5/2025	10:45:00 AM	0.3
11/5/2025	11:00:00 AM	0.3
11/5/2025	11:15:00 AM	0.3
11/5/2025	11:30:00 AM	0.3
11/5/2025	11:45:00 AM	0.3
11/5/2025	12:00:00 PM	0.3
11/5/2025	12:15:00 PM	0.3
11/5/2025	12:30:00 PM	0.3
11/5/2025	12:45:00 PM	0.3
11/5/2025	1:00:00 PM	0.3
11/5/2025	1:15:00 PM	0.3
11/5/2025	1:30:00 PM	0.3
11/5/2025	1:45:00 PM	0.3
11/5/2025	2:00:00 PM	0.3
11/5/2025	2:15:00 PM	0.3
11/5/2025	2:30:00 PM	0.3
11/5/2025	2:45:00 PM	0.3
11/5/2025	3:00:00 PM	0.3
11/5/2025	3:15:00 PM	0.3
11/5/2025	3:30:00 PM	0.3
11/5/2025	3:45:00 PM	0.3
11/5/2025	4:00:00 PM	0.3
11/5/2025	4:15:00 PM	0.3
11/5/2025	4:30:00 PM	0.3
11/5/2025	4:45:00 PM	0.3
11/5/2025	5:00:00 PM	0.3
11/5/2025	5:15:00 PM	0.3
11/5/2025	5:30:00 PM	0.3
11/5/2025	5:45:00 PM	0.3
11/5/2025	6:00:00 PM	0.3
11/5/2025	6:15:00 PM	0.3
11/5/2025	6:30:00 PM	0.3
11/5/2025	6:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/5/2025	7:00:00 PM	0.3
11/5/2025	7:15:00 PM	0.3
11/5/2025	7:30:00 PM	0.3
11/5/2025	7:45:00 PM	0.3
11/5/2025	8:00:00 PM	0.3
11/5/2025	8:15:00 PM	0.3
11/5/2025	8:30:00 PM	0.3
11/5/2025	8:45:00 PM	0.3
11/5/2025	9:00:00 PM	0.29
11/5/2025	9:15:00 PM	0.29
11/5/2025	9:30:00 PM	0.29
11/5/2025	9:45:00 PM	0.29
11/5/2025	10:00:00 PM	0.29
11/5/2025	10:15:00 PM	0.29
11/5/2025	10:30:00 PM	0.29
11/5/2025	10:45:00 PM	0.29
11/5/2025	11:00:00 PM	0.29
11/5/2025	11:15:00 PM	0.29
11/5/2025	11:30:00 PM	0.29
11/5/2025	11:45:00 PM	0.29
11/6/2025	12:00:00 AM	0.29
11/6/2025	12:15:00 AM	0.29
11/6/2025	12:30:00 AM	0.29
11/6/2025	12:45:00 AM	0.29
11/6/2025	1:00:00 AM	0.29
11/6/2025	1:15:00 AM	0.29
11/6/2025	1:30:00 AM	0.29
11/6/2025	1:45:00 AM	0.29
11/6/2025	2:00:00 AM	0.29
11/6/2025	2:15:00 AM	0.29
11/6/2025	2:30:00 AM	0.29
11/6/2025	2:45:00 AM	0.29
11/6/2025	3:00:00 AM	0.29
11/6/2025	3:15:00 AM	0.29
11/6/2025	3:30:00 AM	0.29
11/6/2025	3:45:00 AM	0.29
11/6/2025	4:00:00 AM	0.29
11/6/2025	4:15:00 AM	0.29
11/6/2025	4:30:00 AM	0.29
11/6/2025	4:45:00 AM	0.29
11/6/2025	5:00:00 AM	0.29
11/6/2025	5:15:00 AM	0.29
11/6/2025	5:30:00 AM	0.29
11/6/2025	5:45:00 AM	0.29
11/6/2025	6:00:00 AM	0.29
11/6/2025	6:15:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
11/6/2025	6:30:00 AM	0.29
11/6/2025	6:45:00 AM	0.29
11/6/2025	7:00:00 AM	0.29
11/6/2025	7:15:00 AM	0.29
11/6/2025	7:30:00 AM	0.29
11/6/2025	7:45:00 AM	0.29
11/6/2025	8:00:00 AM	0.29
11/6/2025	8:15:00 AM	0.29
11/6/2025	8:30:00 AM	0.29
11/6/2025	8:45:00 AM	0.29
11/6/2025	9:00:00 AM	0.29
11/6/2025	9:15:00 AM	0.29
11/6/2025	9:30:00 AM	0.29
11/6/2025	9:45:00 AM	0.29
11/6/2025	10:00:00 AM	0.29
11/6/2025	10:15:00 AM	0.29
11/6/2025	10:30:00 AM	0.29
11/6/2025	10:45:00 AM	0.29
11/6/2025	11:00:00 AM	0.29
11/6/2025	11:15:00 AM	0.29
11/6/2025	11:30:00 AM	0.29
11/6/2025	11:45:00 AM	0.29
11/6/2025	12:00:00 PM	0.29
11/6/2025	12:15:00 PM	0.29
11/6/2025	12:30:00 PM	0.29
11/6/2025	12:45:00 PM	0.29
11/6/2025	1:00:00 PM	0.29
11/6/2025	1:15:00 PM	0.29
11/6/2025	1:30:00 PM	0.29
11/6/2025	1:45:00 PM	0.29
11/6/2025	2:00:00 PM	0.29
11/6/2025	2:15:00 PM	0.29
11/6/2025	2:30:00 PM	0.29
11/6/2025	2:45:00 PM	0.29
11/6/2025	3:00:00 PM	0.29
11/6/2025	3:15:00 PM	0.29
11/6/2025	3:30:00 PM	0.29
11/6/2025	3:45:00 PM	0.29
11/6/2025	4:00:00 PM	0.29
11/6/2025	4:15:00 PM	0.29
11/6/2025	4:30:00 PM	0.29
11/6/2025	4:45:00 PM	0.29
11/6/2025	5:00:00 PM	0.29
11/6/2025	5:15:00 PM	0.29
11/6/2025	5:30:00 PM	0.29
11/6/2025	5:45:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
11/6/2025	6:00:00 PM	0.29
11/6/2025	6:15:00 PM	0.29
11/6/2025	6:30:00 PM	0.29
11/6/2025	6:45:00 PM	0.29
11/6/2025	7:00:00 PM	0.29
11/6/2025	7:15:00 PM	0.29
11/6/2025	7:30:00 PM	0.29
11/6/2025	7:45:00 PM	0.29
11/6/2025	8:00:00 PM	0.29
11/6/2025	8:15:00 PM	0.29
11/6/2025	8:30:00 PM	0.29
11/6/2025	8:45:00 PM	0.29
11/6/2025	9:00:00 PM	0.29
11/6/2025	9:15:00 PM	0.29
11/6/2025	9:30:00 PM	0.29
11/6/2025	9:45:00 PM	0.29
11/6/2025	10:00:00 PM	0.29
11/6/2025	10:15:00 PM	0.29
11/6/2025	10:30:00 PM	0.29
11/6/2025	10:45:00 PM	0.29
11/6/2025	11:00:00 PM	0.29
11/6/2025	11:15:00 PM	0.29
11/6/2025	11:30:00 PM	0.29
11/6/2025	11:45:00 PM	0.29
11/7/2025	12:00:00 AM	0.29
11/7/2025	12:15:00 AM	0.29
11/7/2025	12:30:00 AM	0.29
11/7/2025	12:45:00 AM	0.29
11/7/2025	1:00:00 AM	0.29
11/7/2025	1:15:00 AM	0.29
11/7/2025	1:30:00 AM	0.29
11/7/2025	1:45:00 AM	0.29
11/7/2025	2:00:00 AM	0.29
11/7/2025	2:15:00 AM	0.29
11/7/2025	2:30:00 AM	0.29
11/7/2025	2:45:00 AM	0.29
11/7/2025	3:00:00 AM	0.29
11/7/2025	3:15:00 AM	0.29
11/7/2025	3:30:00 AM	0.29
11/7/2025	3:45:00 AM	0.29
11/7/2025	4:00:00 AM	0.29
11/7/2025	4:15:00 AM	0.29
11/7/2025	4:30:00 AM	0.29
11/7/2025	4:45:00 AM	0.29
11/7/2025	5:00:00 AM	0.29
11/7/2025	5:15:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
11/7/2025	5:30:00 AM	0.29
11/7/2025	5:45:00 AM	0.29
11/7/2025	6:00:00 AM	0.29
11/7/2025	6:15:00 AM	0.29
11/7/2025	6:30:00 AM	0.29
11/7/2025	6:45:00 AM	0.29
11/7/2025	7:00:00 AM	0.29
11/7/2025	7:15:00 AM	0.29
11/7/2025	7:30:00 AM	0.29
11/7/2025	7:45:00 AM	0.29
11/7/2025	8:00:00 AM	0.29
11/7/2025	8:15:00 AM	0.29
11/7/2025	8:30:00 AM	0.29
11/7/2025	8:45:00 AM	0.29
11/7/2025	9:00:00 AM	0.29
11/7/2025	9:15:00 AM	0.29
11/7/2025	9:30:00 AM	0.29
11/7/2025	9:45:00 AM	0.29
11/7/2025	10:00:00 AM	0.29
11/7/2025	10:15:00 AM	0.29
11/7/2025	10:30:00 AM	0.29
11/7/2025	10:45:00 AM	0.29
11/7/2025	11:00:00 AM	0.29
11/7/2025	11:15:00 AM	0.29
11/7/2025	11:30:00 AM	0.29
11/7/2025	11:45:00 AM	0.29
11/7/2025	12:00:00 PM	0.29
11/7/2025	12:15:00 PM	0.29
11/7/2025	12:30:00 PM	0.29
11/7/2025	12:45:00 PM	0.29
11/7/2025	1:00:00 PM	0.29
11/7/2025	1:15:00 PM	0.29
11/7/2025	1:30:00 PM	0.29
11/7/2025	1:45:00 PM	0.29
11/7/2025	2:00:00 PM	0.29
11/7/2025	2:15:00 PM	0.29
11/7/2025	2:30:00 PM	0.29
11/7/2025	2:45:00 PM	0.29
11/7/2025	3:00:00 PM	0.29
11/7/2025	3:15:00 PM	0.29
11/7/2025	3:30:00 PM	0.29
11/7/2025	3:45:00 PM	0.29
11/7/2025	4:00:00 PM	0.29
11/7/2025	4:15:00 PM	0.29
11/7/2025	4:30:00 PM	0.29
11/7/2025	4:45:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
11/7/2025	5:00:00 PM	0.29
11/7/2025	5:15:00 PM	0.29
11/7/2025	5:30:00 PM	0.29
11/7/2025	5:45:00 PM	0.29
11/7/2025	6:00:00 PM	0.29
11/7/2025	6:15:00 PM	0.29
11/7/2025	6:30:00 PM	0.29
11/7/2025	6:45:00 PM	0.29
11/7/2025	7:00:00 PM	0.29
11/7/2025	7:15:00 PM	0.29
11/7/2025	7:30:00 PM	0.29
11/7/2025	7:45:00 PM	0.29
11/7/2025	8:00:00 PM	0.29
11/7/2025	8:15:00 PM	0.29
11/7/2025	8:30:00 PM	0.29
11/7/2025	8:45:00 PM	0.29
11/7/2025	9:00:00 PM	0.29
11/7/2025	9:15:00 PM	0.29
11/7/2025	9:30:00 PM	0.29
11/7/2025	9:45:00 PM	0.29
11/7/2025	10:00:00 PM	0.29
11/7/2025	10:15:00 PM	0.29
11/7/2025	10:30:00 PM	0.29
11/7/2025	10:45:00 PM	0.29
11/7/2025	11:00:00 PM	0.29
11/7/2025	11:15:00 PM	0.29
11/7/2025	11:30:00 PM	0.29
11/7/2025	11:45:00 PM	0.29
11/8/2025	12:00:00 AM	0.29
11/8/2025	12:15:00 AM	0.29
11/8/2025	12:30:00 AM	0.29
11/8/2025	12:45:00 AM	0.29
11/8/2025	1:00:00 AM	0.29
11/8/2025	1:15:00 AM	0.29
11/8/2025	1:30:00 AM	0.29
11/8/2025	1:45:00 AM	0.29
11/8/2025	2:00:00 AM	0.29
11/8/2025	2:15:00 AM	0.29
11/8/2025	2:30:00 AM	0.29
11/8/2025	2:45:00 AM	0.29
11/8/2025	3:00:00 AM	0.29
11/8/2025	3:15:00 AM	0.29
11/8/2025	3:30:00 AM	0.29
11/8/2025	3:45:00 AM	0.29
11/8/2025	4:00:00 AM	0.29
11/8/2025	4:15:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
11/8/2025	4:30:00 AM	0.29
11/8/2025	4:45:00 AM	0.29
11/8/2025	5:00:00 AM	0.29
11/8/2025	5:15:00 AM	0.29
11/8/2025	5:30:00 AM	0.29
11/8/2025	5:45:00 AM	0.29
11/8/2025	6:00:00 AM	0.29
11/8/2025	6:15:00 AM	0.29
11/8/2025	6:30:00 AM	0.29
11/8/2025	6:45:00 AM	0.29
11/8/2025	7:00:00 AM	0.29
11/8/2025	7:15:00 AM	0.29
11/8/2025	7:30:00 AM	0.29
11/8/2025	7:45:00 AM	0.29
11/8/2025	8:00:00 AM	0.29
11/8/2025	8:15:00 AM	0.29
11/8/2025	8:30:00 AM	0.29
11/8/2025	8:45:00 AM	0.29
11/8/2025	9:00:00 AM	0.29
11/8/2025	9:15:00 AM	0.29
11/8/2025	9:30:00 AM	0.29
11/8/2025	9:45:00 AM	0.29
11/8/2025	10:00:00 AM	0.29
11/8/2025	10:15:00 AM	0.29
11/8/2025	10:30:00 AM	0.29
11/8/2025	10:45:00 AM	0.29
11/8/2025	11:00:00 AM	0.29
11/8/2025	11:15:00 AM	0.29
11/8/2025	11:30:00 AM	0.29
11/8/2025	11:45:00 AM	0.29
11/8/2025	12:00:00 PM	0.29
11/8/2025	12:15:00 PM	0.29
11/8/2025	12:30:00 PM	0.29
11/8/2025	12:45:00 PM	0.29
11/8/2025	1:00:00 PM	0.29
11/8/2025	1:15:00 PM	0.29
11/8/2025	1:30:00 PM	0.29
11/8/2025	1:45:00 PM	0.29
11/8/2025	2:00:00 PM	0.29
11/8/2025	2:15:00 PM	0.29
11/8/2025	2:30:00 PM	0.3
11/8/2025	2:45:00 PM	0.29
11/8/2025	3:00:00 PM	0.3
11/8/2025	3:15:00 PM	0.3
11/8/2025	3:30:00 PM	0.29
11/8/2025	3:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/8/2025	4:00:00 PM	0.3
11/8/2025	4:15:00 PM	0.3
11/8/2025	4:30:00 PM	0.3
11/8/2025	4:45:00 PM	0.3
11/8/2025	5:00:00 PM	0.3
11/8/2025	5:15:00 PM	0.29
11/8/2025	5:30:00 PM	0.3
11/8/2025	5:45:00 PM	0.3
11/8/2025	6:00:00 PM	0.3
11/8/2025	6:15:00 PM	0.3
11/8/2025	6:30:00 PM	0.3
11/8/2025	6:45:00 PM	0.29
11/8/2025	7:00:00 PM	0.29
11/8/2025	7:15:00 PM	0.3
11/8/2025	7:30:00 PM	0.3
11/8/2025	7:45:00 PM	0.3
11/8/2025	8:00:00 PM	0.29
11/8/2025	8:15:00 PM	0.29
11/8/2025	8:30:00 PM	0.3
11/8/2025	8:45:00 PM	0.3
11/8/2025	9:00:00 PM	0.3
11/8/2025	9:15:00 PM	0.3
11/8/2025	9:30:00 PM	0.3
11/8/2025	9:45:00 PM	0.3
11/8/2025	10:00:00 PM	0.3
11/8/2025	10:15:00 PM	0.3
11/8/2025	10:30:00 PM	0.29
11/8/2025	10:45:00 PM	0.3
11/8/2025	11:00:00 PM	0.3
11/8/2025	11:15:00 PM	0.29
11/8/2025	11:30:00 PM	0.3
11/8/2025	11:45:00 PM	0.3
11/9/2025	12:00:00 AM	0.3
11/9/2025	12:15:00 AM	0.3
11/9/2025	12:30:00 AM	0.3
11/9/2025	12:45:00 AM	0.3
11/9/2025	1:00:00 AM	0.3
11/9/2025	1:15:00 AM	0.3
11/9/2025	1:30:00 AM	0.3
11/9/2025	1:45:00 AM	0.3
11/9/2025	2:00:00 AM	0.3
11/9/2025	2:15:00 AM	0.3
11/9/2025	2:30:00 AM	0.3
11/9/2025	2:45:00 AM	0.3
11/9/2025	3:00:00 AM	0.3
11/9/2025	3:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/9/2025	3:30:00 AM	0.3
11/9/2025	3:45:00 AM	0.3
11/9/2025	4:00:00 AM	0.3
11/9/2025	4:15:00 AM	0.3
11/9/2025	4:30:00 AM	0.3
11/9/2025	4:45:00 AM	0.3
11/9/2025	5:00:00 AM	0.3
11/9/2025	5:15:00 AM	0.3
11/9/2025	5:30:00 AM	0.3
11/9/2025	5:45:00 AM	0.3
11/9/2025	6:00:00 AM	0.3
11/9/2025	6:15:00 AM	0.29
11/9/2025	6:30:00 AM	0.29
11/9/2025	6:45:00 AM	0.29
11/9/2025	7:00:00 AM	0.29
11/9/2025	7:15:00 AM	0.29
11/9/2025	7:30:00 AM	0.29
11/9/2025	7:45:00 AM	0.29
11/9/2025	8:00:00 AM	0.29
11/9/2025	8:15:00 AM	0.29
11/9/2025	8:30:00 AM	0.29
11/9/2025	8:45:00 AM	0.29
11/9/2025	9:00:00 AM	0.29
11/9/2025	9:15:00 AM	0.29
11/9/2025	9:30:00 AM	0.29
11/9/2025	9:45:00 AM	0.29
11/9/2025	10:00:00 AM	0.29
11/9/2025	10:15:00 AM	0.29
11/9/2025	10:30:00 AM	0.29
11/9/2025	10:45:00 AM	0.29
11/9/2025	11:00:00 AM	0.29
11/9/2025	11:15:00 AM	0.29
11/9/2025	11:30:00 AM	0.29
11/9/2025	11:45:00 AM	0.29
11/9/2025	12:00:00 PM	0.29
11/9/2025	12:15:00 PM	0.29
11/9/2025	12:30:00 PM	0.29
11/9/2025	12:45:00 PM	0.29
11/9/2025	1:00:00 PM	0.29
11/9/2025	1:15:00 PM	0.29
11/9/2025	1:30:00 PM	0.29
11/9/2025	1:45:00 PM	0.29
11/9/2025	2:00:00 PM	0.29
11/9/2025	2:15:00 PM	0.29
11/9/2025	2:30:00 PM	0.29
11/9/2025	2:45:00 PM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
11/9/2025	3:00:00 PM	0.29
11/9/2025	3:15:00 PM	0.29
11/9/2025	3:30:00 PM	0.29
11/9/2025	3:45:00 PM	0.29
11/9/2025	4:00:00 PM	0.29
11/9/2025	4:15:00 PM	0.29
11/9/2025	4:30:00 PM	0.29
11/9/2025	4:45:00 PM	0.29
11/9/2025	5:00:00 PM	0.29
11/9/2025	5:15:00 PM	0.29
11/9/2025	5:30:00 PM	0.29
11/9/2025	5:45:00 PM	0.29
11/9/2025	6:00:00 PM	0.29
11/9/2025	6:15:00 PM	0.29
11/9/2025	6:30:00 PM	0.29
11/9/2025	6:45:00 PM	0.29
11/9/2025	7:00:00 PM	0.29
11/9/2025	7:15:00 PM	0.29
11/9/2025	7:30:00 PM	0.29
11/9/2025	7:45:00 PM	0.29
11/9/2025	8:00:00 PM	0.29
11/9/2025	8:15:00 PM	0.29
11/9/2025	8:30:00 PM	0.28
11/9/2025	8:45:00 PM	0.28
11/9/2025	9:00:00 PM	0.28
11/9/2025	9:15:00 PM	0.28
11/9/2025	9:30:00 PM	0.29
11/9/2025	9:45:00 PM	0.28
11/9/2025	10:00:00 PM	0.28
11/9/2025	10:15:00 PM	0.28
11/9/2025	10:30:00 PM	0.28
11/9/2025	10:45:00 PM	0.29
11/9/2025	11:00:00 PM	0.28
11/9/2025	11:15:00 PM	0.29
11/9/2025	11:30:00 PM	0.28
11/9/2025	11:45:00 PM	0.28
11/10/2025	12:00:00 AM	0.28
11/10/2025	12:15:00 AM	0.28
11/10/2025	12:30:00 AM	0.28
11/10/2025	12:45:00 AM	0.28
11/10/2025	1:00:00 AM	0.28
11/10/2025	1:15:00 AM	0.28
11/10/2025	1:30:00 AM	0.28
11/10/2025	1:45:00 AM	0.28
11/10/2025	2:00:00 AM	0.28
11/10/2025	2:15:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
11/10/2025	2:30:00 AM	0.28
11/10/2025	2:45:00 AM	0.28
11/10/2025	3:00:00 AM	0.28
11/10/2025	3:15:00 AM	0.28
11/10/2025	3:30:00 AM	0.28
11/10/2025	3:45:00 AM	0.28
11/10/2025	4:00:00 AM	0.28
11/10/2025	4:15:00 AM	0.28
11/10/2025	4:30:00 AM	0.28
11/10/2025	4:45:00 AM	0.28
11/10/2025	5:00:00 AM	0.28
11/10/2025	5:15:00 AM	0.28
11/10/2025	5:30:00 AM	0.28
11/10/2025	5:45:00 AM	0.27
11/10/2025	6:00:00 AM	0.27
11/10/2025	6:15:00 AM	0.27
11/10/2025	6:30:00 AM	0.27
11/10/2025	6:45:00 AM	0.26
11/10/2025	7:00:00 AM	0.26
11/10/2025	7:15:00 AM	0.26
11/10/2025	7:30:00 AM	0.26
11/10/2025	7:45:00 AM	0.25
11/10/2025	8:00:00 AM	0.25
11/10/2025	8:15:00 AM	0.25
11/10/2025	8:30:00 AM	0.25
11/10/2025	8:45:00 AM	0.25
11/10/2025	9:00:00 AM	0.25
11/10/2025	9:15:00 AM	0.24
11/10/2025	9:30:00 AM	0.24
11/10/2025	9:45:00 AM	0.24
11/10/2025	10:00:00 AM	0.24
11/10/2025	10:15:00 AM	0.24
11/10/2025	10:30:00 AM	0.24
11/10/2025	10:45:00 AM	0.25
11/10/2025	11:00:00 AM	0.25
11/10/2025	11:15:00 AM	0.25
11/10/2025	11:30:00 AM	0.25
11/10/2025	11:45:00 AM	0.26
11/10/2025	12:00:00 PM	0.26
11/10/2025	12:15:00 PM	0.26
11/10/2025	12:30:00 PM	0.26
11/10/2025	12:45:00 PM	0.26
11/10/2025	1:00:00 PM	0.27
11/10/2025	1:15:00 PM	0.27
11/10/2025	1:30:00 PM	0.27
11/10/2025	1:45:00 PM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
11/10/2025	2:00:00 PM	0.27
11/10/2025	2:15:00 PM	0.27
11/10/2025	2:30:00 PM	0.27
11/10/2025	2:45:00 PM	0.28
11/10/2025	3:00:00 PM	0.28
11/10/2025	3:15:00 PM	0.28
11/10/2025	3:30:00 PM	0.28
11/10/2025	3:45:00 PM	0.28
11/10/2025	4:00:00 PM	0.28
11/10/2025	4:15:00 PM	0.28
11/10/2025	4:30:00 PM	0.28
11/10/2025	4:45:00 PM	0.29
11/10/2025	5:00:00 PM	0.29
11/10/2025	5:15:00 PM	0.29
11/10/2025	5:30:00 PM	0.29
11/10/2025	5:45:00 PM	0.29
11/10/2025	6:00:00 PM	0.29
11/10/2025	6:15:00 PM	0.29
11/10/2025	6:30:00 PM	0.29
11/10/2025	6:45:00 PM	0.29
11/10/2025	7:00:00 PM	0.29
11/10/2025	7:15:00 PM	0.29
11/10/2025	7:30:00 PM	0.29
11/10/2025	7:45:00 PM	0.29
11/10/2025	8:00:00 PM	0.29
11/10/2025	8:15:00 PM	0.29
11/10/2025	8:30:00 PM	0.29
11/10/2025	8:45:00 PM	0.29
11/10/2025	9:00:00 PM	0.29
11/10/2025	9:15:00 PM	0.29
11/10/2025	9:30:00 PM	0.3
11/10/2025	9:45:00 PM	0.29
11/10/2025	10:00:00 PM	0.29
11/10/2025	10:15:00 PM	0.3
11/10/2025	10:30:00 PM	0.3
11/10/2025	10:45:00 PM	0.3
11/10/2025	11:00:00 PM	0.3
11/10/2025	11:15:00 PM	0.3
11/10/2025	11:30:00 PM	0.3
11/10/2025	11:45:00 PM	0.3
11/11/2025	12:00:00 AM	0.3
11/11/2025	12:15:00 AM	0.3
11/11/2025	12:30:00 AM	0.3
11/11/2025	12:45:00 AM	0.3
11/11/2025	1:00:00 AM	0.3
11/11/2025	1:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/11/2025	1:30:00 AM	0.3
11/11/2025	1:45:00 AM	0.3
11/11/2025	2:00:00 AM	0.3
11/11/2025	2:15:00 AM	0.3
11/11/2025	2:30:00 AM	0.3
11/11/2025	2:45:00 AM	0.3
11/11/2025	3:00:00 AM	0.3
11/11/2025	3:15:00 AM	0.3
11/11/2025	3:30:00 AM	0.3
11/11/2025	3:45:00 AM	0.3
11/11/2025	4:00:00 AM	0.3
11/11/2025	4:15:00 AM	0.3
11/11/2025	4:30:00 AM	0.3
11/11/2025	4:45:00 AM	0.3
11/11/2025	5:00:00 AM	0.3
11/11/2025	5:15:00 AM	0.3
11/11/2025	5:30:00 AM	0.3
11/11/2025	5:45:00 AM	0.3
11/11/2025	6:00:00 AM	0.3
11/11/2025	6:15:00 AM	0.3
11/11/2025	6:30:00 AM	0.3
11/11/2025	6:45:00 AM	0.3
11/11/2025	7:00:00 AM	0.3
11/11/2025	7:15:00 AM	0.3
11/11/2025	7:30:00 AM	0.3
11/11/2025	7:45:00 AM	0.3
11/11/2025	8:00:00 AM	0.3
11/11/2025	8:15:00 AM	0.3
11/11/2025	8:30:00 AM	0.3
11/11/2025	8:45:00 AM	0.3
11/11/2025	9:00:00 AM	0.3
11/11/2025	9:15:00 AM	0.3
11/11/2025	9:30:00 AM	0.3
11/11/2025	9:45:00 AM	0.3
11/11/2025	10:00:00 AM	0.3
11/11/2025	10:15:00 AM	0.3
11/11/2025	10:30:00 AM	0.3
11/11/2025	10:45:00 AM	0.3
11/11/2025	11:00:00 AM	0.3
11/11/2025	11:15:00 AM	0.3
11/11/2025	11:30:00 AM	0.3
11/11/2025	11:45:00 AM	0.3
11/11/2025	12:00:00 PM	0.3
11/11/2025	12:15:00 PM	0.3
11/11/2025	12:30:00 PM	0.3
11/11/2025	12:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/11/2025	1:00:00 PM	0.3
11/11/2025	1:15:00 PM	0.3
11/11/2025	1:30:00 PM	0.3
11/11/2025	1:45:00 PM	0.3
11/11/2025	2:00:00 PM	0.3
11/11/2025	2:15:00 PM	0.3
11/11/2025	2:30:00 PM	0.3
11/11/2025	2:45:00 PM	0.3
11/11/2025	3:00:00 PM	0.3
11/11/2025	3:15:00 PM	0.3
11/11/2025	3:30:00 PM	0.3
11/11/2025	3:45:00 PM	0.3
11/11/2025	4:00:00 PM	0.3
11/11/2025	4:15:00 PM	0.3
11/11/2025	4:30:00 PM	0.3
11/11/2025	4:45:00 PM	0.3
11/11/2025	5:00:00 PM	0.3
11/11/2025	5:15:00 PM	0.3
11/11/2025	5:30:00 PM	0.3
11/11/2025	5:45:00 PM	0.3
11/11/2025	6:00:00 PM	0.3
11/11/2025	6:15:00 PM	0.3
11/11/2025	6:30:00 PM	0.3
11/11/2025	6:45:00 PM	0.3
11/11/2025	7:00:00 PM	0.3
11/11/2025	7:15:00 PM	0.3
11/11/2025	7:30:00 PM	0.3
11/11/2025	7:45:00 PM	0.3
11/11/2025	8:00:00 PM	0.3
11/11/2025	8:15:00 PM	0.3
11/11/2025	8:30:00 PM	0.3
11/11/2025	8:45:00 PM	0.3
11/11/2025	9:00:00 PM	0.3
11/11/2025	9:15:00 PM	0.3
11/11/2025	9:30:00 PM	0.3
11/11/2025	9:45:00 PM	0.3
11/11/2025	10:00:00 PM	0.3
11/11/2025	10:15:00 PM	0.3
11/11/2025	10:30:00 PM	0.3
11/11/2025	10:45:00 PM	0.3
11/11/2025	11:00:00 PM	0.3
11/11/2025	11:15:00 PM	0.3
11/11/2025	11:30:00 PM	0.3
11/11/2025	11:45:00 PM	0.3
11/12/2025	12:00:00 AM	0.3
11/12/2025	12:15:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/12/2025	12:30:00 AM	0.3
11/12/2025	12:45:00 AM	0.3
11/12/2025	1:00:00 AM	0.3
11/12/2025	1:15:00 AM	0.3
11/12/2025	1:30:00 AM	0.3
11/12/2025	1:45:00 AM	0.3
11/12/2025	2:00:00 AM	0.3
11/12/2025	2:15:00 AM	0.3
11/12/2025	2:30:00 AM	0.3
11/12/2025	2:45:00 AM	0.3
11/12/2025	3:00:00 AM	0.3
11/12/2025	3:15:00 AM	0.3
11/12/2025	3:30:00 AM	0.3
11/12/2025	3:45:00 AM	0.3
11/12/2025	4:00:00 AM	0.3
11/12/2025	4:15:00 AM	0.3
11/12/2025	4:30:00 AM	0.3
11/12/2025	4:45:00 AM	0.3
11/12/2025	5:00:00 AM	0.3
11/12/2025	5:15:00 AM	0.3
11/12/2025	5:30:00 AM	0.3
11/12/2025	5:45:00 AM	0.3
11/12/2025	6:00:00 AM	0.3
11/12/2025	6:15:00 AM	0.3
11/12/2025	6:30:00 AM	0.3
11/12/2025	6:45:00 AM	0.3
11/12/2025	7:00:00 AM	0.3
11/12/2025	7:15:00 AM	0.3
11/12/2025	7:30:00 AM	0.3
11/12/2025	7:45:00 AM	0.3
11/12/2025	8:00:00 AM	0.3
11/12/2025	8:15:00 AM	0.3
11/12/2025	8:30:00 AM	0.3
11/12/2025	8:45:00 AM	0.3
11/12/2025	9:00:00 AM	0.3
11/12/2025	9:15:00 AM	0.3
11/12/2025	9:30:00 AM	0.3
11/12/2025	9:45:00 AM	0.3
11/12/2025	10:00:00 AM	0.3
11/12/2025	10:15:00 AM	0.3
11/12/2025	10:30:00 AM	0.3
11/12/2025	10:45:00 AM	0.3
11/12/2025	11:00:00 AM	0.3
11/12/2025	11:15:00 AM	0.3
11/12/2025	11:30:00 AM	0.3
11/12/2025	11:45:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/12/2025	12:00:00 PM	0.3
11/12/2025	12:15:00 PM	0.3
11/12/2025	12:30:00 PM	0.3
11/12/2025	12:45:00 PM	0.3
11/12/2025	1:00:00 PM	0.3
11/12/2025	1:15:00 PM	0.3
11/12/2025	1:30:00 PM	0.3
11/12/2025	1:45:00 PM	0.3
11/12/2025	2:00:00 PM	0.3
11/12/2025	2:15:00 PM	0.3
11/12/2025	2:30:00 PM	0.3
11/12/2025	2:45:00 PM	0.3
11/12/2025	3:00:00 PM	0.3
11/12/2025	3:15:00 PM	0.3
11/12/2025	3:30:00 PM	0.3
11/12/2025	3:45:00 PM	0.3
11/12/2025	4:00:00 PM	0.3
11/12/2025	4:15:00 PM	0.3
11/12/2025	4:30:00 PM	0.3
11/12/2025	4:45:00 PM	0.3
11/12/2025	5:00:00 PM	0.3
11/12/2025	5:15:00 PM	0.3
11/12/2025	5:30:00 PM	0.3
11/12/2025	5:45:00 PM	0.3
11/12/2025	6:00:00 PM	0.3
11/12/2025	6:15:00 PM	0.3
11/12/2025	6:30:00 PM	0.3
11/12/2025	6:45:00 PM	0.3
11/12/2025	7:00:00 PM	0.3
11/12/2025	7:15:00 PM	0.3
11/12/2025	7:30:00 PM	0.3
11/12/2025	7:45:00 PM	0.3
11/12/2025	8:00:00 PM	0.3
11/12/2025	8:15:00 PM	0.3
11/12/2025	8:30:00 PM	0.3
11/12/2025	8:45:00 PM	0.3
11/12/2025	9:00:00 PM	0.3
11/12/2025	9:15:00 PM	0.3
11/12/2025	9:30:00 PM	0.3
11/12/2025	9:45:00 PM	0.3
11/12/2025	10:00:00 PM	0.3
11/12/2025	10:15:00 PM	0.3
11/12/2025	10:30:00 PM	0.3
11/12/2025	10:45:00 PM	0.3
11/12/2025	11:00:00 PM	0.3
11/12/2025	11:15:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
11/12/2025	11:30:00 PM	0.3
11/12/2025	11:45:00 PM	0.3
11/13/2025	12:00:00 AM	0.3
11/13/2025	12:15:00 AM	0.3
11/13/2025	12:30:00 AM	0.3
11/13/2025	12:45:00 AM	0.3
11/13/2025	1:00:00 AM	0.3
11/13/2025	1:15:00 AM	0.3
11/13/2025	1:30:00 AM	0.3
11/13/2025	1:45:00 AM	0.3
11/13/2025	2:00:00 AM	0.3
11/13/2025	2:15:00 AM	0.3
11/13/2025	2:30:00 AM	0.3
11/13/2025	2:45:00 AM	0.3
11/13/2025	3:00:00 AM	0.3
11/13/2025	3:15:00 AM	0.3
11/13/2025	3:30:00 AM	0.3
11/13/2025	3:45:00 AM	0.3
11/13/2025	4:00:00 AM	0.3
11/13/2025	4:15:00 AM	0.3
11/13/2025	4:30:00 AM	0.3
11/13/2025	4:45:00 AM	0.3
11/13/2025	5:00:00 AM	0.3
11/13/2025	5:15:00 AM	0.3
11/13/2025	5:30:00 AM	0.3
11/13/2025	5:45:00 AM	0.3
11/13/2025	6:00:00 AM	0.3
11/13/2025	6:15:00 AM	0.3
11/13/2025	6:30:00 AM	0.29
11/13/2025	6:45:00 AM	0.29
11/13/2025	7:00:00 AM	0.29
11/13/2025	7:15:00 AM	0.29
11/13/2025	7:30:00 AM	0.29
11/13/2025	7:45:00 AM	0.29
11/13/2025	8:00:00 AM	0.29
11/13/2025	8:15:00 AM	0.29
11/13/2025	8:30:00 AM	0.29
11/13/2025	8:45:00 AM	0.29
11/13/2025	9:00:00 AM	0.29
11/13/2025	9:15:00 AM	0.29
11/13/2025	9:30:00 AM	0.29
11/13/2025	9:45:00 AM	0.29
11/13/2025	10:00:00 AM	0.28
11/13/2025	10:15:00 AM	0.28
11/13/2025	10:30:00 AM	0.28
11/13/2025	10:45:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
11/13/2025	11:00:00 AM	0.28
11/13/2025	11:15:00 AM	0.28
11/13/2025	11:30:00 AM	0.28
11/13/2025	11:45:00 AM	0.28
11/13/2025	12:00:00 PM	0.28
11/13/2025	12:15:00 PM	0.28
11/13/2025	12:30:00 PM	0.28
11/13/2025	12:45:00 PM	0.28
11/13/2025	1:00:00 PM	0.28
11/13/2025	1:15:00 PM	0.28
11/13/2025	1:30:00 PM	0.28
11/13/2025	1:45:00 PM	0.28
11/13/2025	2:00:00 PM	0.28
11/13/2025	2:15:00 PM	0.28
11/13/2025	2:30:00 PM	0.28
11/13/2025	2:45:00 PM	0.27
11/13/2025	3:00:00 PM	0.27
11/13/2025	3:15:00 PM	0.27
11/13/2025	3:30:00 PM	0.27
11/13/2025	3:45:00 PM	0.27
11/13/2025	4:00:00 PM	0.27
11/13/2025	4:15:00 PM	0.27
11/13/2025	4:30:00 PM	0.27
11/13/2025	4:45:00 PM	0.27
11/13/2025	5:00:00 PM	0.27
11/13/2025	5:15:00 PM	0.27
11/13/2025	5:30:00 PM	0.27
11/13/2025	5:45:00 PM	0.27
11/13/2025	6:00:00 PM	0.27
11/13/2025	6:15:00 PM	0.27
11/13/2025	6:30:00 PM	0.27
11/13/2025	6:45:00 PM	0.27
11/13/2025	7:00:00 PM	0.27
11/13/2025	7:15:00 PM	0.27
11/13/2025	7:30:00 PM	0.27
11/13/2025	7:45:00 PM	0.27
11/13/2025	8:00:00 PM	0.27
11/13/2025	8:15:00 PM	0.27
11/13/2025	8:30:00 PM	0.27
11/13/2025	8:45:00 PM	0.27
11/13/2025	9:00:00 PM	0.27
11/13/2025	9:15:00 PM	0.27
11/13/2025	9:30:00 PM	0.27
11/13/2025	9:45:00 PM	0.27
11/13/2025	10:00:00 PM	0.27
11/13/2025	10:15:00 PM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
11/13/2025	10:30:00 PM	0.27
11/13/2025	10:45:00 PM	0.27
11/13/2025	11:00:00 PM	0.27
11/13/2025	11:15:00 PM	0.27
11/13/2025	11:30:00 PM	0.27
11/13/2025	11:45:00 PM	0.27
11/14/2025	12:00:00 AM	0.27
11/14/2025	12:15:00 AM	0.27
11/14/2025	12:30:00 AM	0.27
11/14/2025	12:45:00 AM	0.27
11/14/2025	1:00:00 AM	0.27
11/14/2025	1:15:00 AM	0.27
11/14/2025	1:30:00 AM	0.27
11/14/2025	1:45:00 AM	0.27
11/14/2025	2:00:00 AM	0.27
11/14/2025	2:15:00 AM	0.27
11/14/2025	2:30:00 AM	0.27
11/14/2025	2:45:00 AM	0.27
11/14/2025	3:00:00 AM	0.27
11/14/2025	3:15:00 AM	0.27
11/14/2025	3:30:00 AM	0.27
11/14/2025	3:45:00 AM	0.27
11/14/2025	4:00:00 AM	0.27
11/14/2025	4:15:00 AM	0.27
11/14/2025	4:30:00 AM	0.27
11/14/2025	4:45:00 AM	0.27
11/14/2025	5:00:00 AM	0.27
11/14/2025	5:15:00 AM	0.27
11/14/2025	5:30:00 AM	0.27
11/14/2025	5:45:00 AM	0.27
11/14/2025	6:00:00 AM	0.27
11/14/2025	6:15:00 AM	0.27
11/14/2025	6:30:00 AM	0.28
11/14/2025	6:45:00 AM	0.28
11/14/2025	7:00:00 AM	0.28
11/14/2025	7:15:00 AM	0.28
11/14/2025	7:30:00 AM	0.28
11/14/2025	7:45:00 AM	0.28
11/14/2025	8:00:00 AM	0.29
11/14/2025	8:15:00 AM	0.29
11/14/2025	8:30:00 AM	0.29
11/14/2025	8:45:00 AM	0.29
11/14/2025	9:00:00 AM	0.29
11/14/2025	9:15:00 AM	0.29
11/14/2025	9:30:00 AM	0.29
11/14/2025	9:45:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
11/14/2025	10:00:00 AM	0.29
11/14/2025	10:15:00 AM	0.29
11/14/2025	10:30:00 AM	0.29
11/14/2025	10:45:00 AM	0.29
11/14/2025	11:00:00 AM	0.29
11/14/2025	11:15:00 AM	0.3
11/14/2025	11:30:00 AM	0.3
11/14/2025	11:45:00 AM	0.3
11/14/2025	12:00:00 PM	0.3
11/14/2025	12:15:00 PM	0.3
11/14/2025	12:30:00 PM	0.3
11/14/2025	12:45:00 PM	0.3
11/14/2025	1:00:00 PM	0.3
11/14/2025	1:15:00 PM	0.3
11/14/2025	1:30:00 PM	0.3
11/14/2025	1:45:00 PM	0.3
11/14/2025	2:00:00 PM	0.3
11/14/2025	2:15:00 PM	0.3
11/14/2025	2:30:00 PM	0.3
11/14/2025	2:45:00 PM	0.3
11/14/2025	3:00:00 PM	0.3
11/14/2025	3:15:00 PM	0.3
11/14/2025	3:30:00 PM	0.3
11/14/2025	3:45:00 PM	0.3
11/14/2025	4:00:00 PM	0.3
11/14/2025	4:15:00 PM	0.3
11/14/2025	4:30:00 PM	0.3
11/14/2025	4:45:00 PM	0.3
11/14/2025	5:00:00 PM	0.31
11/14/2025	5:15:00 PM	0.31
11/14/2025	5:30:00 PM	0.31
11/14/2025	5:45:00 PM	0.31
11/14/2025	6:00:00 PM	0.31
11/14/2025	6:15:00 PM	0.31
11/14/2025	6:30:00 PM	0.31
11/14/2025	6:45:00 PM	0.31
11/14/2025	7:00:00 PM	0.31
11/14/2025	7:15:00 PM	0.31
11/14/2025	7:30:00 PM	0.31
11/14/2025	7:45:00 PM	0.31
11/14/2025	8:00:00 PM	0.31
11/14/2025	8:15:00 PM	0.31
11/14/2025	8:30:00 PM	0.31
11/14/2025	8:45:00 PM	0.31
11/14/2025	9:00:00 PM	0.31
11/14/2025	9:15:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
11/14/2025	9:30:00 PM	0.31
11/14/2025	9:45:00 PM	0.31
11/14/2025	10:00:00 PM	0.31
11/14/2025	10:15:00 PM	0.31
11/14/2025	10:30:00 PM	0.31
11/14/2025	10:45:00 PM	0.31
11/14/2025	11:00:00 PM	0.31
11/14/2025	11:15:00 PM	0.31
11/14/2025	11:30:00 PM	0.31
11/14/2025	11:45:00 PM	0.31
11/15/2025	12:00:00 AM	0.31
11/15/2025	12:15:00 AM	0.31
11/15/2025	12:30:00 AM	0.31
11/15/2025	12:45:00 AM	0.31
11/15/2025	1:00:00 AM	0.31
11/15/2025	1:15:00 AM	0.31
11/15/2025	1:30:00 AM	0.31
11/15/2025	1:45:00 AM	0.31
11/15/2025	2:00:00 AM	0.31
11/15/2025	2:15:00 AM	0.31
11/15/2025	2:30:00 AM	0.31
11/15/2025	2:45:00 AM	0.31
11/15/2025	3:00:00 AM	0.31
11/15/2025	3:15:00 AM	0.31
11/15/2025	3:30:00 AM	0.31
11/15/2025	3:45:00 AM	0.31
11/15/2025	4:00:00 AM	0.31
11/15/2025	4:15:00 AM	0.32
11/15/2025	4:30:00 AM	0.31
11/15/2025	4:45:00 AM	0.31
11/15/2025	5:00:00 AM	0.31
11/15/2025	5:15:00 AM	0.31
11/15/2025	5:30:00 AM	0.31
11/15/2025	5:45:00 AM	0.31
11/15/2025	6:00:00 AM	0.32
11/15/2025	6:15:00 AM	0.32
11/15/2025	6:30:00 AM	0.32
11/15/2025	6:45:00 AM	0.32
11/15/2025	7:00:00 AM	0.32
11/15/2025	7:15:00 AM	0.32
11/15/2025	7:30:00 AM	0.32
11/15/2025	7:45:00 AM	0.32
11/15/2025	8:00:00 AM	0.32
11/15/2025	8:15:00 AM	0.32
11/15/2025	8:30:00 AM	0.32
11/15/2025	8:45:00 AM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
11/15/2025	9:00:00 AM	0.31
11/15/2025	9:15:00 AM	0.32
11/15/2025	9:30:00 AM	0.31
11/15/2025	9:45:00 AM	0.32
11/15/2025	10:00:00 AM	0.31
11/15/2025	10:15:00 AM	0.32
11/15/2025	10:30:00 AM	0.32
11/15/2025	10:45:00 AM	0.32
11/15/2025	11:00:00 AM	0.32
11/15/2025	11:15:00 AM	0.32
11/15/2025	11:30:00 AM	0.32
11/15/2025	11:45:00 AM	0.32
11/15/2025	12:00:00 PM	0.32
11/15/2025	12:15:00 PM	0.32
11/15/2025	12:30:00 PM	0.32
11/15/2025	12:45:00 PM	0.32
11/15/2025	1:00:00 PM	0.32
11/15/2025	1:15:00 PM	0.32
11/15/2025	1:30:00 PM	0.32
11/15/2025	1:45:00 PM	0.32
11/15/2025	2:00:00 PM	0.32
11/15/2025	2:15:00 PM	0.32
11/15/2025	2:30:00 PM	0.32
11/15/2025	2:45:00 PM	0.32
11/15/2025	3:00:00 PM	0.32
11/15/2025	3:15:00 PM	0.32
11/15/2025	3:30:00 PM	0.33
11/15/2025	3:45:00 PM	0.33
11/15/2025	4:00:00 PM	0.33
11/15/2025	4:15:00 PM	0.33
11/15/2025	4:30:00 PM	0.33
11/15/2025	4:45:00 PM	0.33
11/15/2025	5:00:00 PM	0.33
11/15/2025	5:15:00 PM	0.33
11/15/2025	5:30:00 PM	0.33
11/15/2025	5:45:00 PM	0.33
11/15/2025	6:00:00 PM	0.33
11/15/2025	6:15:00 PM	0.33
11/15/2025	6:30:00 PM	0.33
11/15/2025	6:45:00 PM	0.33
11/15/2025	7:00:00 PM	0.33
11/15/2025	7:15:00 PM	0.33
11/15/2025	7:30:00 PM	0.33
11/15/2025	7:45:00 PM	0.33
11/15/2025	8:00:00 PM	0.33
11/15/2025	8:15:00 PM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
11/15/2025	8:30:00 PM	0.33
11/15/2025	8:45:00 PM	0.33
11/15/2025	9:00:00 PM	0.33
11/15/2025	9:15:00 PM	0.33
11/15/2025	9:30:00 PM	0.34
11/15/2025	9:45:00 PM	0.34
11/15/2025	10:00:00 PM	0.34
11/15/2025	10:15:00 PM	0.34
11/15/2025	10:30:00 PM	0.34
11/15/2025	10:45:00 PM	0.33
11/15/2025	11:00:00 PM	0.33
11/15/2025	11:15:00 PM	0.33
11/15/2025	11:30:00 PM	0.33
11/15/2025	11:45:00 PM	0.33
11/16/2025	12:00:00 AM	0.33
11/16/2025	12:15:00 AM	0.33
11/16/2025	12:30:00 AM	0.33
11/16/2025	12:45:00 AM	0.33
11/16/2025	1:00:00 AM	0.33
11/16/2025	1:15:00 AM	0.33
11/16/2025	1:30:00 AM	0.33
11/16/2025	1:45:00 AM	0.33
11/16/2025	2:00:00 AM	0.33
11/16/2025	2:15:00 AM	0.33
11/16/2025	2:30:00 AM	0.33
11/16/2025	2:45:00 AM	0.33
11/16/2025	3:00:00 AM	0.33
11/16/2025	3:15:00 AM	0.33
11/16/2025	3:30:00 AM	0.33
11/16/2025	3:45:00 AM	0.33
11/16/2025	4:00:00 AM	0.33
11/16/2025	4:15:00 AM	0.33
11/16/2025	4:30:00 AM	0.33
11/16/2025	4:45:00 AM	0.33
11/16/2025	5:00:00 AM	0.33
11/16/2025	5:15:00 AM	0.33
11/16/2025	5:30:00 AM	0.33
11/16/2025	5:45:00 AM	0.33
11/16/2025	6:00:00 AM	0.33
11/16/2025	6:15:00 AM	0.33
11/16/2025	6:30:00 AM	0.33
11/16/2025	6:45:00 AM	0.33
11/16/2025	7:00:00 AM	0.33
11/16/2025	7:15:00 AM	0.33
11/16/2025	7:30:00 AM	0.33
11/16/2025	7:45:00 AM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
11/16/2025	8:00:00 AM	0.33
11/16/2025	8:15:00 AM	0.33
11/16/2025	8:30:00 AM	0.33
11/16/2025	8:45:00 AM	0.33
11/16/2025	9:00:00 AM	0.33
11/16/2025	9:15:00 AM	0.33
11/16/2025	9:30:00 AM	0.33
11/16/2025	9:45:00 AM	0.33
11/16/2025	10:00:00 AM	0.33
11/16/2025	10:15:00 AM	0.33
11/16/2025	10:30:00 AM	0.33
11/16/2025	10:45:00 AM	0.33
11/16/2025	11:00:00 AM	0.33
11/16/2025	11:15:00 AM	0.33
11/16/2025	11:30:00 AM	0.33
11/16/2025	11:45:00 AM	0.33
11/16/2025	12:00:00 PM	0.33
11/16/2025	12:15:00 PM	0.33
11/16/2025	12:30:00 PM	0.33
11/16/2025	12:45:00 PM	0.33
11/16/2025	1:00:00 PM	0.33
11/16/2025	1:15:00 PM	0.33
11/16/2025	1:30:00 PM	0.33
11/16/2025	1:45:00 PM	0.33
11/16/2025	2:00:00 PM	0.33
11/16/2025	2:15:00 PM	0.33
11/16/2025	2:30:00 PM	0.33
11/16/2025	2:45:00 PM	0.33
11/16/2025	3:00:00 PM	0.33
11/16/2025	3:15:00 PM	0.33
11/16/2025	3:30:00 PM	0.33
11/16/2025	3:45:00 PM	0.33
11/16/2025	4:00:00 PM	0.33
11/16/2025	4:15:00 PM	0.33
11/16/2025	4:30:00 PM	0.33
11/16/2025	4:45:00 PM	0.33
11/16/2025	5:00:00 PM	0.33
11/16/2025	5:15:00 PM	0.33
11/16/2025	5:30:00 PM	0.33
11/16/2025	5:45:00 PM	0.33
11/16/2025	6:00:00 PM	0.33
11/16/2025	6:15:00 PM	0.33
11/16/2025	6:30:00 PM	0.33
11/16/2025	6:45:00 PM	0.33
11/16/2025	7:00:00 PM	0.33
11/16/2025	7:15:00 PM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
11/16/2025	7:30:00 PM	0.33
11/16/2025	7:45:00 PM	0.33
11/16/2025	8:00:00 PM	0.33
11/16/2025	8:15:00 PM	0.33
11/16/2025	8:30:00 PM	0.33
11/16/2025	8:45:00 PM	0.33
11/16/2025	9:00:00 PM	0.33
11/16/2025	9:15:00 PM	0.33
11/16/2025	9:30:00 PM	0.33
11/16/2025	9:45:00 PM	0.33
11/16/2025	10:00:00 PM	0.33
11/16/2025	10:15:00 PM	0.33
11/16/2025	10:30:00 PM	0.33
11/16/2025	10:45:00 PM	0.33
11/16/2025	11:00:00 PM	0.33
11/16/2025	11:15:00 PM	0.33
11/16/2025	11:30:00 PM	0.33
11/16/2025	11:45:00 PM	0.33
11/17/2025	12:00:00 AM	0.33
11/17/2025	12:15:00 AM	0.33
11/17/2025	12:30:00 AM	0.33
11/17/2025	12:45:00 AM	0.33
11/17/2025	1:00:00 AM	0.33
11/17/2025	1:15:00 AM	0.33
11/17/2025	1:30:00 AM	0.33
11/17/2025	1:45:00 AM	0.33
11/17/2025	2:00:00 AM	0.33
11/17/2025	2:15:00 AM	0.33
11/17/2025	2:30:00 AM	0.33
11/17/2025	2:45:00 AM	0.33
11/17/2025	3:00:00 AM	0.33
11/17/2025	3:15:00 AM	0.33
11/17/2025	3:30:00 AM	0.33
11/17/2025	3:45:00 AM	0.33
11/17/2025	4:00:00 AM	0.33
11/17/2025	4:15:00 AM	0.33
11/17/2025	4:30:00 AM	0.33
11/17/2025	4:45:00 AM	0.33
11/17/2025	5:00:00 AM	0.33
11/17/2025	5:15:00 AM	0.33
11/17/2025	5:30:00 AM	0.33
11/17/2025	5:45:00 AM	0.33
11/17/2025	6:00:00 AM	0.33
11/17/2025	6:15:00 AM	0.33
11/17/2025	6:30:00 AM	0.33
11/17/2025	6:45:00 AM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
11/17/2025	7:00:00 AM	0.33
11/17/2025	7:15:00 AM	0.33
11/17/2025	7:30:00 AM	0.33
11/17/2025	7:45:00 AM	0.33
11/17/2025	8:00:00 AM	0.33
11/17/2025	8:15:00 AM	0.33
11/17/2025	8:30:00 AM	0.33
11/17/2025	8:45:00 AM	0.33
11/17/2025	9:00:00 AM	0.33
11/17/2025	9:15:00 AM	0.33
11/17/2025	9:30:00 AM	0.33
11/17/2025	9:45:00 AM	0.33
11/17/2025	10:00:00 AM	0.33
11/17/2025	10:15:00 AM	0.33
11/17/2025	10:30:00 AM	0.33
11/17/2025	10:45:00 AM	0.33
11/17/2025	11:00:00 AM	0.33
11/17/2025	11:15:00 AM	0.33
11/17/2025	11:30:00 AM	0.33
11/17/2025	11:45:00 AM	0.33
11/17/2025	12:00:00 PM	0.33
11/17/2025	12:15:00 PM	0.33
11/17/2025	12:30:00 PM	0.33
11/17/2025	12:45:00 PM	0.33
11/17/2025	1:00:00 PM	0.33
11/17/2025	1:15:00 PM	0.33
11/17/2025	1:30:00 PM	0.33
11/17/2025	1:45:00 PM	0.33
11/17/2025	2:00:00 PM	0.33
11/17/2025	2:15:00 PM	0.33
11/17/2025	2:30:00 PM	0.33
11/17/2025	2:45:00 PM	0.33
11/17/2025	3:00:00 PM	0.33
11/17/2025	3:15:00 PM	0.33
11/17/2025	3:30:00 PM	0.33
11/17/2025	3:45:00 PM	0.33
11/17/2025	4:00:00 PM	0.33
11/17/2025	4:15:00 PM	0.33
11/17/2025	4:30:00 PM	0.33
11/17/2025	4:45:00 PM	0.33
11/17/2025	5:00:00 PM	0.33
11/17/2025	5:15:00 PM	0.33
11/17/2025	5:30:00 PM	0.33
11/17/2025	5:45:00 PM	0.33
11/17/2025	6:00:00 PM	0.33
11/17/2025	6:15:00 PM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
11/17/2025	6:30:00 PM	0.33
11/17/2025	6:45:00 PM	0.33
11/17/2025	7:00:00 PM	0.33
11/17/2025	7:15:00 PM	0.33
11/17/2025	7:30:00 PM	0.33
11/17/2025	7:45:00 PM	0.33
11/17/2025	8:00:00 PM	0.33
11/17/2025	8:15:00 PM	0.33
11/17/2025	8:30:00 PM	0.33
11/17/2025	8:45:00 PM	0.33
11/17/2025	9:00:00 PM	0.33
11/17/2025	9:15:00 PM	0.34
11/17/2025	9:30:00 PM	0.34
11/17/2025	9:45:00 PM	0.34
11/17/2025	10:00:00 PM	0.34
11/17/2025	10:15:00 PM	0.34
11/17/2025	10:30:00 PM	0.34
11/17/2025	10:45:00 PM	0.34
11/17/2025	11:00:00 PM	0.34
11/17/2025	11:15:00 PM	0.34
11/17/2025	11:30:00 PM	0.34
11/17/2025	11:45:00 PM	0.34
11/18/2025	12:00:00 AM	0.34
11/18/2025	12:15:00 AM	0.34
11/18/2025	12:30:00 AM	0.34
11/18/2025	12:45:00 AM	0.34
11/18/2025	1:00:00 AM	0.34
11/18/2025	1:15:00 AM	0.34
11/18/2025	1:30:00 AM	0.34
11/18/2025	1:45:00 AM	0.34
11/18/2025	2:00:00 AM	0.34
11/18/2025	2:15:00 AM	0.34
11/18/2025	2:30:00 AM	0.34
11/18/2025	2:45:00 AM	0.34
11/18/2025	3:00:00 AM	0.34
11/18/2025	3:15:00 AM	0.34
11/18/2025	3:30:00 AM	0.34
11/18/2025	3:45:00 AM	0.34
11/18/2025	4:00:00 AM	0.34
11/18/2025	4:15:00 AM	0.34
11/18/2025	4:30:00 AM	0.34
11/18/2025	4:45:00 AM	0.34
11/18/2025	5:00:00 AM	0.34
11/18/2025	5:15:00 AM	0.34
11/18/2025	5:30:00 AM	0.34
11/18/2025	5:45:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/18/2025	6:00:00 AM	0.34
11/18/2025	6:15:00 AM	0.34
11/18/2025	6:30:00 AM	0.34
11/18/2025	6:45:00 AM	0.34
11/18/2025	7:00:00 AM	0.34
11/18/2025	7:15:00 AM	0.34
11/18/2025	7:30:00 AM	0.34
11/18/2025	7:45:00 AM	0.34
11/18/2025	8:00:00 AM	0.34
11/18/2025	8:15:00 AM	0.34
11/18/2025	8:30:00 AM	0.34
11/18/2025	8:45:00 AM	0.34
11/18/2025	9:00:00 AM	0.34
11/18/2025	9:15:00 AM	0.34
11/18/2025	9:30:00 AM	0.34
11/18/2025	9:45:00 AM	0.34
11/18/2025	10:00:00 AM	0.34
11/18/2025	10:15:00 AM	0.34
11/18/2025	10:30:00 AM	0.34
11/18/2025	10:45:00 AM	0.34
11/18/2025	11:00:00 AM	0.34
11/18/2025	11:15:00 AM	0.34
11/18/2025	11:30:00 AM	0.34
11/18/2025	11:45:00 AM	0.34
11/18/2025	12:00:00 PM	0.34
11/18/2025	12:15:00 PM	0.34
11/18/2025	12:30:00 PM	0.34
11/18/2025	12:45:00 PM	0.34
11/18/2025	1:00:00 PM	0.34
11/18/2025	1:15:00 PM	0.34
11/18/2025	1:30:00 PM	0.34
11/18/2025	1:45:00 PM	0.34
11/18/2025	2:00:00 PM	0.34
11/18/2025	2:15:00 PM	0.34
11/18/2025	2:30:00 PM	0.34
11/18/2025	2:45:00 PM	0.34
11/18/2025	3:00:00 PM	0.34
11/18/2025	3:15:00 PM	0.34
11/18/2025	3:30:00 PM	0.34
11/18/2025	3:45:00 PM	0.34
11/18/2025	4:00:00 PM	0.34
11/18/2025	4:15:00 PM	0.34
11/18/2025	4:30:00 PM	0.34
11/18/2025	4:45:00 PM	0.34
11/18/2025	5:00:00 PM	0.34
11/18/2025	5:15:00 PM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/18/2025	5:30:00 PM	0.34
11/18/2025	5:45:00 PM	0.34
11/18/2025	6:00:00 PM	0.34
11/18/2025	6:15:00 PM	0.34
11/18/2025	6:30:00 PM	0.34
11/18/2025	6:45:00 PM	0.34
11/18/2025	7:00:00 PM	0.34
11/18/2025	7:15:00 PM	0.34
11/18/2025	7:30:00 PM	0.34
11/18/2025	7:45:00 PM	0.34
11/18/2025	8:00:00 PM	0.34
11/18/2025	8:15:00 PM	0.34
11/18/2025	8:30:00 PM	0.34
11/18/2025	8:45:00 PM	0.34
11/18/2025	9:00:00 PM	0.34
11/18/2025	9:15:00 PM	0.34
11/18/2025	9:30:00 PM	0.34
11/18/2025	9:45:00 PM	0.34
11/18/2025	10:00:00 PM	0.34
11/18/2025	10:15:00 PM	0.34
11/18/2025	10:30:00 PM	0.34
11/18/2025	10:45:00 PM	0.34
11/18/2025	11:00:00 PM	0.34
11/18/2025	11:15:00 PM	0.34
11/18/2025	11:30:00 PM	0.34
11/18/2025	11:45:00 PM	0.34
11/19/2025	12:00:00 AM	0.34
11/19/2025	12:15:00 AM	0.34
11/19/2025	12:30:00 AM	0.34
11/19/2025	12:45:00 AM	0.34
11/19/2025	1:00:00 AM	0.34
11/19/2025	1:15:00 AM	0.34
11/19/2025	1:30:00 AM	0.34
11/19/2025	1:45:00 AM	0.34
11/19/2025	2:00:00 AM	0.34
11/19/2025	2:15:00 AM	0.34
11/19/2025	2:30:00 AM	0.34
11/19/2025	2:45:00 AM	0.34
11/19/2025	3:00:00 AM	0.34
11/19/2025	3:15:00 AM	0.34
11/19/2025	3:30:00 AM	0.34
11/19/2025	3:45:00 AM	0.34
11/19/2025	4:00:00 AM	0.34
11/19/2025	4:15:00 AM	0.34
11/19/2025	4:30:00 AM	0.34
11/19/2025	4:45:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/19/2025	5:00:00 AM	0.34
11/19/2025	5:15:00 AM	0.34
11/19/2025	5:30:00 AM	0.34
11/19/2025	5:45:00 AM	0.34
11/19/2025	6:00:00 AM	0.34
11/19/2025	6:15:00 AM	0.34
11/19/2025	6:30:00 AM	0.34
11/19/2025	6:45:00 AM	0.34
11/19/2025	7:00:00 AM	0.34
11/19/2025	7:15:00 AM	0.34
11/19/2025	7:30:00 AM	0.34
11/19/2025	7:45:00 AM	0.34
11/19/2025	8:00:00 AM	0.34
11/19/2025	8:15:00 AM	0.34
11/19/2025	8:30:00 AM	0.34
11/19/2025	8:45:00 AM	0.34
11/19/2025	9:00:00 AM	0.34
11/19/2025	9:15:00 AM	0.34
11/19/2025	9:30:00 AM	0.34
11/19/2025	9:45:00 AM	0.34
11/19/2025	10:00:00 AM	0.34
11/19/2025	10:15:00 AM	0.34
11/19/2025	10:30:00 AM	0.34
11/19/2025	10:45:00 AM	0.34
11/19/2025	11:00:00 AM	0.34
11/19/2025	11:15:00 AM	0.34
11/19/2025	11:30:00 AM	0.34
11/19/2025	11:45:00 AM	0.34
11/19/2025	12:00:00 PM	0.34
11/19/2025	12:15:00 PM	0.34
11/19/2025	12:30:00 PM	0.34
11/19/2025	12:45:00 PM	0.34
11/19/2025	1:00:00 PM	0.34
11/19/2025	1:15:00 PM	0.34
11/19/2025	1:30:00 PM	0.34
11/19/2025	1:45:00 PM	0.34
11/19/2025	2:00:00 PM	0.34
11/19/2025	2:15:00 PM	0.34
11/19/2025	2:30:00 PM	0.34
11/19/2025	2:45:00 PM	0.34
11/19/2025	3:00:00 PM	0.34
11/19/2025	3:15:00 PM	0.34
11/19/2025	3:30:00 PM	0.34
11/19/2025	3:45:00 PM	0.34
11/19/2025	4:00:00 PM	0.34
11/19/2025	4:15:00 PM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/19/2025	4:30:00 PM	0.34
11/19/2025	4:45:00 PM	0.34
11/19/2025	5:00:00 PM	0.34
11/19/2025	5:15:00 PM	0.34
11/19/2025	5:30:00 PM	0.34
11/19/2025	5:45:00 PM	0.34
11/19/2025	6:00:00 PM	0.34
11/19/2025	6:15:00 PM	0.34
11/19/2025	6:30:00 PM	0.34
11/19/2025	6:45:00 PM	0.34
11/19/2025	7:00:00 PM	0.34
11/19/2025	7:15:00 PM	0.34
11/19/2025	7:30:00 PM	0.34
11/19/2025	7:45:00 PM	0.34
11/19/2025	8:00:00 PM	0.34
11/19/2025	8:15:00 PM	0.34
11/19/2025	8:30:00 PM	0.34
11/19/2025	8:45:00 PM	0.34
11/19/2025	9:00:00 PM	0.34
11/19/2025	9:15:00 PM	0.34
11/19/2025	9:30:00 PM	0.34
11/19/2025	9:45:00 PM	0.34
11/19/2025	10:00:00 PM	0.34
11/19/2025	10:15:00 PM	0.34
11/19/2025	10:30:00 PM	0.34
11/19/2025	10:45:00 PM	0.34
11/19/2025	11:00:00 PM	0.34
11/19/2025	11:15:00 PM	0.34
11/19/2025	11:30:00 PM	0.34
11/19/2025	11:45:00 PM	0.34
11/20/2025	12:00:00 AM	0.34
11/20/2025	12:15:00 AM	0.34
11/20/2025	12:30:00 AM	0.34
11/20/2025	12:45:00 AM	0.34
11/20/2025	1:00:00 AM	0.34
11/20/2025	1:15:00 AM	0.34
11/20/2025	1:30:00 AM	0.34
11/20/2025	1:45:00 AM	0.34
11/20/2025	2:00:00 AM	0.34
11/20/2025	2:15:00 AM	0.34
11/20/2025	2:30:00 AM	0.34
11/20/2025	2:45:00 AM	0.34
11/20/2025	3:00:00 AM	0.34
11/20/2025	3:15:00 AM	0.34
11/20/2025	3:30:00 AM	0.34
11/20/2025	3:45:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/20/2025	4:00:00 AM	0.34
11/20/2025	4:15:00 AM	0.34
11/20/2025	4:30:00 AM	0.34
11/20/2025	4:45:00 AM	0.34
11/20/2025	5:00:00 AM	0.34
11/20/2025	5:15:00 AM	0.34
11/20/2025	5:30:00 AM	0.34
11/20/2025	5:45:00 AM	0.34
11/20/2025	6:00:00 AM	0.34
11/20/2025	6:15:00 AM	0.34
11/20/2025	6:30:00 AM	0.34
11/20/2025	6:45:00 AM	0.34
11/20/2025	7:00:00 AM	0.34
11/20/2025	7:15:00 AM	0.34
11/20/2025	7:30:00 AM	0.34
11/20/2025	7:45:00 AM	0.34
11/20/2025	8:00:00 AM	0.34
11/20/2025	8:15:00 AM	0.34
11/20/2025	8:30:00 AM	0.34
11/20/2025	8:45:00 AM	0.34
11/20/2025	9:00:00 AM	0.34
11/20/2025	9:15:00 AM	0.34
11/20/2025	9:30:00 AM	0.34
11/20/2025	9:45:00 AM	0.34
11/20/2025	10:00:00 AM	0.34
11/20/2025	10:15:00 AM	0.34
11/20/2025	10:30:00 AM	0.34
11/20/2025	10:45:00 AM	0.34
11/20/2025	11:00:00 AM	0.34
11/20/2025	11:15:00 AM	0.34
11/20/2025	11:30:00 AM	0.34
11/20/2025	11:45:00 AM	0.34
11/20/2025	12:00:00 PM	0.34
11/20/2025	12:15:00 PM	0.34
11/20/2025	12:30:00 PM	0.34
11/20/2025	12:45:00 PM	0.34
11/20/2025	1:00:00 PM	0.34
11/20/2025	1:15:00 PM	0.34
11/20/2025	1:30:00 PM	0.34
11/20/2025	1:45:00 PM	0.34
11/20/2025	2:00:00 PM	0.34
11/20/2025	2:15:00 PM	0.34
11/20/2025	2:30:00 PM	0.34
11/20/2025	2:45:00 PM	0.34
11/20/2025	3:00:00 PM	0.34
11/20/2025	3:15:00 PM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/20/2025	3:30:00 PM	0.35
11/20/2025	3:45:00 PM	0.35
11/20/2025	4:00:00 PM	0.35
11/20/2025	4:15:00 PM	0.35
11/20/2025	4:30:00 PM	0.35
11/20/2025	4:45:00 PM	0.35
11/20/2025	5:00:00 PM	0.35
11/20/2025	5:15:00 PM	0.35
11/20/2025	5:30:00 PM	0.35
11/20/2025	5:45:00 PM	0.35
11/20/2025	6:00:00 PM	0.35
11/20/2025	6:15:00 PM	0.35
11/20/2025	6:30:00 PM	0.35
11/20/2025	6:45:00 PM	0.35
11/20/2025	7:00:00 PM	0.35
11/20/2025	7:15:00 PM	0.35
11/20/2025	7:30:00 PM	0.35
11/20/2025	7:45:00 PM	0.35
11/20/2025	8:00:00 PM	0.35
11/20/2025	8:15:00 PM	0.35
11/20/2025	8:30:00 PM	0.35
11/20/2025	8:45:00 PM	0.35
11/20/2025	9:00:00 PM	0.35
11/20/2025	9:15:00 PM	0.35
11/20/2025	9:30:00 PM	0.35
11/20/2025	9:45:00 PM	0.35
11/20/2025	10:00:00 PM	0.35
11/20/2025	10:15:00 PM	0.35
11/20/2025	10:30:00 PM	0.35
11/20/2025	10:45:00 PM	0.35
11/20/2025	11:00:00 PM	0.35
11/20/2025	11:15:00 PM	0.35
11/20/2025	11:30:00 PM	0.35
11/20/2025	11:45:00 PM	0.35
11/21/2025	12:00:00 AM	0.35
11/21/2025	12:15:00 AM	0.35
11/21/2025	12:30:00 AM	0.35
11/21/2025	12:45:00 AM	0.35
11/21/2025	1:00:00 AM	0.35
11/21/2025	1:15:00 AM	0.35
11/21/2025	1:30:00 AM	0.35
11/21/2025	1:45:00 AM	0.35
11/21/2025	2:00:00 AM	0.34
11/21/2025	2:15:00 AM	0.35
11/21/2025	2:30:00 AM	0.35
11/21/2025	2:45:00 AM	0.35

Billy Lake Return Gage

DATE	TIME	GAGE
11/21/2025	3:00:00 AM	0.35
11/21/2025	3:15:00 AM	0.35
11/21/2025	3:30:00 AM	0.35
11/21/2025	3:45:00 AM	0.35
11/21/2025	4:00:00 AM	0.34
11/21/2025	4:15:00 AM	0.34
11/21/2025	4:30:00 AM	0.35
11/21/2025	4:45:00 AM	0.35
11/21/2025	5:00:00 AM	0.35
11/21/2025	5:15:00 AM	0.35
11/21/2025	5:30:00 AM	0.35
11/21/2025	5:45:00 AM	0.35
11/21/2025	6:00:00 AM	0.34
11/21/2025	6:15:00 AM	0.34
11/21/2025	6:30:00 AM	0.34
11/21/2025	6:45:00 AM	0.34
11/21/2025	7:00:00 AM	0.34
11/21/2025	7:15:00 AM	0.34
11/21/2025	7:30:00 AM	0.34
11/21/2025	7:45:00 AM	0.35
11/21/2025	8:00:00 AM	0.35
11/21/2025	8:15:00 AM	0.35
11/21/2025	8:30:00 AM	0.35
11/21/2025	8:45:00 AM	0.35
11/21/2025	9:00:00 AM	0.35
11/21/2025	9:15:00 AM	0.35
11/21/2025	9:30:00 AM	0.35
11/21/2025	9:45:00 AM	0.35
11/21/2025	10:00:00 AM	0.35
11/21/2025	10:15:00 AM	0.35
11/21/2025	10:30:00 AM	0.35
11/21/2025	10:45:00 AM	0.35
11/21/2025	11:00:00 AM	0.35
11/21/2025	11:15:00 AM	0.35
11/21/2025	11:30:00 AM	0.35
11/21/2025	11:45:00 AM	0.35
11/21/2025	12:00:00 PM	0.35
11/21/2025	12:15:00 PM	0.35
11/21/2025	12:30:00 PM	0.35
11/21/2025	12:45:00 PM	0.35
11/21/2025	1:00:00 PM	0.35
11/21/2025	1:15:00 PM	0.35
11/21/2025	1:30:00 PM	0.35
11/21/2025	1:45:00 PM	0.35
11/21/2025	2:00:00 PM	0.35
11/21/2025	2:15:00 PM	0.35

Billy Lake Return Gage

DATE	TIME	GAGE
11/21/2025	2:30:00 PM	0.35
11/21/2025	2:45:00 PM	0.35
11/21/2025	3:00:00 PM	0.35
11/21/2025	3:15:00 PM	0.35
11/21/2025	3:30:00 PM	0.35
11/21/2025	3:45:00 PM	0.35
11/21/2025	4:00:00 PM	0.35
11/21/2025	4:15:00 PM	0.35
11/21/2025	4:30:00 PM	0.35
11/21/2025	4:45:00 PM	0.35
11/21/2025	5:00:00 PM	0.35
11/21/2025	5:15:00 PM	0.35
11/21/2025	5:30:00 PM	0.35
11/21/2025	5:45:00 PM	0.35
11/21/2025	6:00:00 PM	0.35
11/21/2025	6:15:00 PM	0.35
11/21/2025	6:30:00 PM	0.35
11/21/2025	6:45:00 PM	0.35
11/21/2025	7:00:00 PM	0.35
11/21/2025	7:15:00 PM	0.35
11/21/2025	7:30:00 PM	0.35
11/21/2025	7:45:00 PM	0.35
11/21/2025	8:00:00 PM	0.35
11/21/2025	8:15:00 PM	0.35
11/21/2025	8:30:00 PM	0.35
11/21/2025	8:45:00 PM	0.35
11/21/2025	9:00:00 PM	0.35
11/21/2025	9:15:00 PM	0.35
11/21/2025	9:30:00 PM	0.34
11/21/2025	9:45:00 PM	0.35
11/21/2025	10:00:00 PM	0.35
11/21/2025	10:15:00 PM	0.35
11/21/2025	10:30:00 PM	0.34
11/21/2025	10:45:00 PM	0.34
11/21/2025	11:00:00 PM	0.35
11/21/2025	11:15:00 PM	0.34
11/21/2025	11:30:00 PM	0.34
11/21/2025	11:45:00 PM	0.34
11/22/2025	12:00:00 AM	0.34
11/22/2025	12:15:00 AM	0.34
11/22/2025	12:30:00 AM	0.34
11/22/2025	12:45:00 AM	0.34
11/22/2025	1:00:00 AM	0.34
11/22/2025	1:15:00 AM	0.34
11/22/2025	1:30:00 AM	0.34
11/22/2025	1:45:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/22/2025	2:00:00 AM	0.34
11/22/2025	2:15:00 AM	0.34
11/22/2025	2:30:00 AM	0.34
11/22/2025	2:45:00 AM	0.34
11/22/2025	3:00:00 AM	0.34
11/22/2025	3:15:00 AM	0.34
11/22/2025	3:30:00 AM	0.34
11/22/2025	3:45:00 AM	0.34
11/22/2025	4:00:00 AM	0.34
11/22/2025	4:15:00 AM	0.34
11/22/2025	4:30:00 AM	0.34
11/22/2025	4:45:00 AM	0.34
11/22/2025	5:00:00 AM	0.34
11/22/2025	5:15:00 AM	0.34
11/22/2025	5:30:00 AM	0.34
11/22/2025	5:45:00 AM	0.34
11/22/2025	6:00:00 AM	0.34
11/22/2025	6:15:00 AM	0.34
11/22/2025	6:30:00 AM	0.34
11/22/2025	6:45:00 AM	0.34
11/22/2025	7:00:00 AM	0.34
11/22/2025	7:15:00 AM	0.34
11/22/2025	7:30:00 AM	0.34
11/22/2025	7:45:00 AM	0.34
11/22/2025	8:00:00 AM	0.34
11/22/2025	8:15:00 AM	0.34
11/22/2025	8:30:00 AM	0.34
11/22/2025	8:45:00 AM	0.34
11/22/2025	9:00:00 AM	0.34
11/22/2025	9:15:00 AM	0.34
11/22/2025	9:30:00 AM	0.34
11/22/2025	9:45:00 AM	0.34
11/22/2025	10:00:00 AM	0.34
11/22/2025	10:15:00 AM	0.34
11/22/2025	10:30:00 AM	0.34
11/22/2025	10:45:00 AM	0.34
11/22/2025	11:00:00 AM	0.34
11/22/2025	11:15:00 AM	0.34
11/22/2025	11:30:00 AM	0.34
11/22/2025	11:45:00 AM	0.34
11/22/2025	12:00:00 PM	0.34
11/22/2025	12:15:00 PM	0.34
11/22/2025	12:30:00 PM	0.34
11/22/2025	12:45:00 PM	0.34
11/22/2025	1:00:00 PM	0.34
11/22/2025	1:15:00 PM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/22/2025	1:30:00 PM	0.34
11/22/2025	1:45:00 PM	0.34
11/22/2025	2:00:00 PM	0.34
11/22/2025	2:15:00 PM	0.34
11/22/2025	2:30:00 PM	0.34
11/22/2025	2:45:00 PM	0.34
11/22/2025	3:00:00 PM	0.34
11/22/2025	3:15:00 PM	0.34
11/22/2025	3:30:00 PM	0.34
11/22/2025	3:45:00 PM	0.34
11/22/2025	4:00:00 PM	0.34
11/22/2025	4:15:00 PM	0.34
11/22/2025	4:30:00 PM	0.34
11/22/2025	4:45:00 PM	0.34
11/22/2025	5:00:00 PM	0.34
11/22/2025	5:15:00 PM	0.34
11/22/2025	5:30:00 PM	0.34
11/22/2025	5:45:00 PM	0.34
11/22/2025	6:00:00 PM	0.34
11/22/2025	6:15:00 PM	0.34
11/22/2025	6:30:00 PM	0.34
11/22/2025	6:45:00 PM	0.34
11/22/2025	7:00:00 PM	0.34
11/22/2025	7:15:00 PM	0.34
11/22/2025	7:30:00 PM	0.34
11/22/2025	7:45:00 PM	0.34
11/22/2025	8:00:00 PM	0.34
11/22/2025	8:15:00 PM	0.34
11/22/2025	8:30:00 PM	0.34
11/22/2025	8:45:00 PM	0.34
11/22/2025	9:00:00 PM	0.34
11/22/2025	9:15:00 PM	0.34
11/22/2025	9:30:00 PM	0.34
11/22/2025	9:45:00 PM	0.34
11/22/2025	10:00:00 PM	0.34
11/22/2025	10:15:00 PM	0.34
11/22/2025	10:30:00 PM	0.34
11/22/2025	10:45:00 PM	0.34
11/22/2025	11:00:00 PM	0.34
11/22/2025	11:15:00 PM	0.34
11/22/2025	11:30:00 PM	0.34
11/22/2025	11:45:00 PM	0.34
11/23/2025	12:00:00 AM	0.34
11/23/2025	12:15:00 AM	0.34
11/23/2025	12:30:00 AM	0.34
11/23/2025	12:45:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/23/2025	1:00:00 AM	0.34
11/23/2025	1:15:00 AM	0.34
11/23/2025	1:30:00 AM	0.34
11/23/2025	1:45:00 AM	0.34
11/23/2025	2:00:00 AM	0.34
11/23/2025	2:15:00 AM	0.34
11/23/2025	2:30:00 AM	0.34
11/23/2025	2:45:00 AM	0.34
11/23/2025	3:00:00 AM	0.34
11/23/2025	3:15:00 AM	0.34
11/23/2025	3:30:00 AM	0.34
11/23/2025	3:45:00 AM	0.34
11/23/2025	4:00:00 AM	0.34
11/23/2025	4:15:00 AM	0.34
11/23/2025	4:30:00 AM	0.34
11/23/2025	4:45:00 AM	0.34
11/23/2025	5:00:00 AM	0.34
11/23/2025	5:15:00 AM	0.34
11/23/2025	5:30:00 AM	0.34
11/23/2025	5:45:00 AM	0.34
11/23/2025	6:00:00 AM	0.34
11/23/2025	6:15:00 AM	0.34
11/23/2025	6:30:00 AM	0.34
11/23/2025	6:45:00 AM	0.34
11/23/2025	7:00:00 AM	0.34
11/23/2025	7:15:00 AM	0.34
11/23/2025	7:30:00 AM	0.34
11/23/2025	7:45:00 AM	0.34
11/23/2025	8:00:00 AM	0.34
11/23/2025	8:15:00 AM	0.34
11/23/2025	8:30:00 AM	0.34
11/23/2025	8:45:00 AM	0.34
11/23/2025	9:00:00 AM	0.34
11/23/2025	9:15:00 AM	0.34
11/23/2025	9:30:00 AM	0.34
11/23/2025	9:45:00 AM	0.34
11/23/2025	10:00:00 AM	0.34
11/23/2025	10:15:00 AM	0.34
11/23/2025	10:30:00 AM	0.34
11/23/2025	10:45:00 AM	0.34
11/23/2025	11:00:00 AM	0.34
11/23/2025	11:15:00 AM	0.34
11/23/2025	11:30:00 AM	0.34
11/23/2025	11:45:00 AM	0.34
11/23/2025	12:00:00 PM	0.34
11/23/2025	12:15:00 PM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/23/2025	12:30:00 PM	0.34
11/23/2025	12:45:00 PM	0.34
11/23/2025	1:00:00 PM	0.34
11/23/2025	1:15:00 PM	0.34
11/23/2025	1:30:00 PM	0.34
11/23/2025	1:45:00 PM	0.34
11/23/2025	2:00:00 PM	0.34
11/23/2025	2:15:00 PM	0.34
11/23/2025	2:30:00 PM	0.34
11/23/2025	2:45:00 PM	0.34
11/23/2025	3:00:00 PM	0.34
11/23/2025	3:15:00 PM	0.34
11/23/2025	3:30:00 PM	0.34
11/23/2025	3:45:00 PM	0.34
11/23/2025	4:00:00 PM	0.34
11/23/2025	4:15:00 PM	0.34
11/23/2025	4:30:00 PM	0.34
11/23/2025	4:45:00 PM	0.34
11/23/2025	5:00:00 PM	0.34
11/23/2025	5:15:00 PM	0.34
11/23/2025	5:30:00 PM	0.34
11/23/2025	5:45:00 PM	0.34
11/23/2025	6:00:00 PM	0.34
11/23/2025	6:15:00 PM	0.34
11/23/2025	6:30:00 PM	0.34
11/23/2025	6:45:00 PM	0.34
11/23/2025	7:00:00 PM	0.34
11/23/2025	7:15:00 PM	0.34
11/23/2025	7:30:00 PM	0.34
11/23/2025	7:45:00 PM	0.34
11/23/2025	8:00:00 PM	0.34
11/23/2025	8:15:00 PM	0.34
11/23/2025	8:30:00 PM	0.34
11/23/2025	8:45:00 PM	0.34
11/23/2025	9:00:00 PM	0.34
11/23/2025	9:15:00 PM	0.34
11/23/2025	9:30:00 PM	0.34
11/23/2025	9:45:00 PM	0.34
11/23/2025	10:00:00 PM	0.34
11/23/2025	10:15:00 PM	0.34
11/23/2025	10:30:00 PM	0.34
11/23/2025	10:45:00 PM	0.34
11/23/2025	11:00:00 PM	0.34
11/23/2025	11:15:00 PM	0.34
11/23/2025	11:30:00 PM	0.34
11/23/2025	11:45:00 PM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/24/2025	12:00:00 AM	0.34
11/24/2025	12:15:00 AM	0.34
11/24/2025	12:30:00 AM	0.34
11/24/2025	12:45:00 AM	0.34
11/24/2025	1:00:00 AM	0.34
11/24/2025	1:15:00 AM	0.34
11/24/2025	1:30:00 AM	0.34
11/24/2025	1:45:00 AM	0.34
11/24/2025	2:00:00 AM	0.34
11/24/2025	2:15:00 AM	0.34
11/24/2025	2:30:00 AM	0.34
11/24/2025	2:45:00 AM	0.34
11/24/2025	3:00:00 AM	0.34
11/24/2025	3:15:00 AM	0.34
11/24/2025	3:30:00 AM	0.34
11/24/2025	3:45:00 AM	0.34
11/24/2025	4:00:00 AM	0.34
11/24/2025	4:15:00 AM	0.34
11/24/2025	4:30:00 AM	0.34
11/24/2025	4:45:00 AM	0.34
11/24/2025	5:00:00 AM	0.34
11/24/2025	5:15:00 AM	0.34
11/24/2025	5:30:00 AM	0.34
11/24/2025	5:45:00 AM	0.34
11/24/2025	6:00:00 AM	0.34
11/24/2025	6:15:00 AM	0.34
11/24/2025	6:30:00 AM	0.34
11/24/2025	6:45:00 AM	0.34
11/24/2025	7:00:00 AM	0.34
11/24/2025	7:15:00 AM	0.34
11/24/2025	7:30:00 AM	0.34
11/24/2025	7:45:00 AM	0.34
11/24/2025	8:00:00 AM	0.34
11/24/2025	8:15:00 AM	0.34
11/24/2025	8:30:00 AM	0.34
11/24/2025	8:45:00 AM	0.34
11/24/2025	9:00:00 AM	0.34
11/24/2025	9:15:00 AM	0.34
11/24/2025	9:30:00 AM	0.34
11/24/2025	9:45:00 AM	0.34
11/24/2025	10:00:00 AM	0.34
11/24/2025	10:15:00 AM	0.34
11/24/2025	10:30:00 AM	0.34
11/24/2025	10:45:00 AM	0.34
11/24/2025	11:00:00 AM	0.34
11/24/2025	11:15:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/24/2025	11:30:00 AM	0.34
11/24/2025	11:45:00 AM	0.34
11/24/2025	12:00:00 PM	0.34
11/24/2025	12:15:00 PM	0.34
11/24/2025	12:30:00 PM	0.34
11/24/2025	12:45:00 PM	0.34
11/24/2025	1:00:00 PM	0.34
11/24/2025	1:15:00 PM	0.34
11/24/2025	1:30:00 PM	0.34
11/24/2025	1:45:00 PM	0.34
11/24/2025	2:00:00 PM	0.34
11/24/2025	2:15:00 PM	0.33
11/24/2025	2:30:00 PM	0.33
11/24/2025	2:45:00 PM	0.33
11/24/2025	3:00:00 PM	0.33
11/24/2025	3:15:00 PM	0.33
11/24/2025	3:30:00 PM	0.33
11/24/2025	3:45:00 PM	0.33
11/24/2025	4:00:00 PM	0.33
11/24/2025	4:15:00 PM	0.33
11/24/2025	4:30:00 PM	0.33
11/24/2025	4:45:00 PM	0.33
11/24/2025	5:00:00 PM	0.33
11/24/2025	5:15:00 PM	0.33
11/24/2025	5:30:00 PM	0.33
11/24/2025	5:45:00 PM	0.33
11/24/2025	6:00:00 PM	0.33
11/24/2025	6:15:00 PM	0.33
11/24/2025	6:30:00 PM	0.33
11/24/2025	6:45:00 PM	0.33
11/24/2025	7:00:00 PM	0.33
11/24/2025	7:15:00 PM	0.33
11/24/2025	7:30:00 PM	0.33
11/24/2025	7:45:00 PM	0.33
11/24/2025	8:00:00 PM	0.33
11/24/2025	8:15:00 PM	0.33
11/24/2025	8:30:00 PM	0.33
11/24/2025	8:45:00 PM	0.33
11/24/2025	9:00:00 PM	0.33
11/24/2025	9:15:00 PM	0.33
11/24/2025	9:30:00 PM	0.33
11/24/2025	9:45:00 PM	0.33
11/24/2025	10:00:00 PM	0.33
11/24/2025	10:15:00 PM	0.33
11/24/2025	10:30:00 PM	0.33
11/24/2025	10:45:00 PM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
11/24/2025	11:00:00 PM	0.33
11/24/2025	11:15:00 PM	0.33
11/24/2025	11:30:00 PM	0.33
11/24/2025	11:45:00 PM	0.33
11/25/2025	12:00:00 AM	0.33
11/25/2025	12:15:00 AM	0.33
11/25/2025	12:30:00 AM	0.33
11/25/2025	12:45:00 AM	0.33
11/25/2025	1:00:00 AM	0.33
11/25/2025	1:15:00 AM	0.33
11/25/2025	1:30:00 AM	0.33
11/25/2025	1:45:00 AM	0.33
11/25/2025	2:00:00 AM	0.33
11/25/2025	2:15:00 AM	0.33
11/25/2025	2:30:00 AM	0.33
11/25/2025	2:45:00 AM	0.33
11/25/2025	3:00:00 AM	0.33
11/25/2025	3:15:00 AM	0.33
11/25/2025	3:30:00 AM	0.33
11/25/2025	3:45:00 AM	0.33
11/25/2025	4:00:00 AM	0.33
11/25/2025	4:15:00 AM	0.33
11/25/2025	4:30:00 AM	0.33
11/25/2025	4:45:00 AM	0.33
11/25/2025	5:00:00 AM	0.33
11/25/2025	5:15:00 AM	0.33
11/25/2025	5:30:00 AM	0.33
11/25/2025	5:45:00 AM	0.33
11/25/2025	6:00:00 AM	0.33
11/25/2025	6:15:00 AM	0.33
11/25/2025	6:30:00 AM	0.33
11/25/2025	6:45:00 AM	0.33
11/25/2025	7:00:00 AM	0.33
11/25/2025	7:15:00 AM	0.33
11/25/2025	7:30:00 AM	0.33
11/25/2025	7:45:00 AM	0.33
11/25/2025	8:00:00 AM	0.33
11/25/2025	8:15:00 AM	0.33
11/25/2025	8:30:00 AM	0.33
11/25/2025	8:45:00 AM	0.33
11/25/2025	9:00:00 AM	0.33
11/25/2025	9:15:00 AM	0.33
11/25/2025	9:30:00 AM	0.33
11/25/2025	9:45:00 AM	0.33
11/25/2025	10:00:00 AM	0.33
11/25/2025	10:15:00 AM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
11/25/2025	10:30:00 AM	0.33
11/25/2025	10:45:00 AM	0.33
11/25/2025	11:00:00 AM	0.33
11/25/2025	11:15:00 AM	0.33
11/25/2025	11:30:00 AM	0.33
11/25/2025	11:45:00 AM	0.33
11/25/2025	12:00:00 PM	0.33
11/25/2025	12:15:00 PM	0.33
11/25/2025	12:30:00 PM	0.33
11/25/2025	12:45:00 PM	0.33
11/25/2025	1:00:00 PM	0.33
11/25/2025	1:15:00 PM	0.33
11/25/2025	1:30:00 PM	0.33
11/25/2025	1:45:00 PM	0.33
11/25/2025	2:00:00 PM	0.33
11/25/2025	2:15:00 PM	0.33
11/25/2025	2:30:00 PM	0.33
11/25/2025	2:45:00 PM	0.33
11/25/2025	3:00:00 PM	0.33
11/25/2025	3:15:00 PM	0.33
11/25/2025	3:30:00 PM	0.33
11/25/2025	3:45:00 PM	0.33
11/25/2025	4:00:00 PM	0.33
11/25/2025	4:15:00 PM	0.33
11/25/2025	4:30:00 PM	0.33
11/25/2025	4:45:00 PM	0.33
11/25/2025	5:00:00 PM	0.33
11/25/2025	5:15:00 PM	0.33
11/25/2025	5:30:00 PM	0.33
11/25/2025	5:45:00 PM	0.33
11/25/2025	6:00:00 PM	0.33
11/25/2025	6:15:00 PM	0.33
11/25/2025	6:30:00 PM	0.33
11/25/2025	6:45:00 PM	0.33
11/25/2025	7:00:00 PM	0.33
11/25/2025	7:15:00 PM	0.33
11/25/2025	7:30:00 PM	0.33
11/25/2025	7:45:00 PM	0.33
11/25/2025	8:00:00 PM	0.33
11/25/2025	8:15:00 PM	0.33
11/25/2025	8:30:00 PM	0.33
11/25/2025	8:45:00 PM	0.33
11/25/2025	9:00:00 PM	0.33
11/25/2025	9:15:00 PM	0.33
11/25/2025	9:30:00 PM	0.33
11/25/2025	9:45:00 PM	0.33

Billy Lake Return Gage

DATE	TIME	GAGE
11/25/2025	10:00:00 PM	0.33
11/25/2025	10:15:00 PM	0.33
11/25/2025	10:30:00 PM	0.33
11/25/2025	10:45:00 PM	0.33
11/25/2025	11:00:00 PM	0.33
11/25/2025	11:15:00 PM	0.33
11/25/2025	11:30:00 PM	0.33
11/25/2025	11:45:00 PM	0.33
11/26/2025	12:00:00 AM	0.33
11/26/2025	12:15:00 AM	0.33
11/26/2025	12:30:00 AM	0.33
11/26/2025	12:45:00 AM	0.33
11/26/2025	1:00:00 AM	0.33
11/26/2025	1:15:00 AM	0.33
11/26/2025	1:30:00 AM	0.33
11/26/2025	1:45:00 AM	0.33
11/26/2025	2:00:00 AM	0.33
11/26/2025	2:15:00 AM	0.33
11/26/2025	2:30:00 AM	0.33
11/26/2025	2:45:00 AM	0.33
11/26/2025	3:00:00 AM	0.33
11/26/2025	3:15:00 AM	0.33
11/26/2025	3:30:00 AM	0.33
11/26/2025	3:45:00 AM	0.33
11/26/2025	4:00:00 AM	0.33
11/26/2025	4:15:00 AM	0.33
11/26/2025	4:30:00 AM	0.33
11/26/2025	4:45:00 AM	0.33
11/26/2025	5:00:00 AM	0.33
11/26/2025	5:15:00 AM	0.34
11/26/2025	5:30:00 AM	0.34
11/26/2025	5:45:00 AM	0.33
11/26/2025	6:00:00 AM	0.34
11/26/2025	6:15:00 AM	0.34
11/26/2025	6:30:00 AM	0.34
11/26/2025	6:45:00 AM	0.34
11/26/2025	7:00:00 AM	0.34
11/26/2025	7:15:00 AM	0.34
11/26/2025	7:30:00 AM	0.34
11/26/2025	7:45:00 AM	0.34
11/26/2025	8:00:00 AM	0.34
11/26/2025	8:15:00 AM	0.34
11/26/2025	8:30:00 AM	0.34
11/26/2025	8:45:00 AM	0.34
11/26/2025	9:00:00 AM	0.34
11/26/2025	9:15:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/26/2025	9:30:00 AM	0.34
11/26/2025	9:45:00 AM	0.34
11/26/2025	10:00:00 AM	0.34
11/26/2025	10:15:00 AM	0.34
11/26/2025	10:30:00 AM	0.34
11/26/2025	10:45:00 AM	0.34
11/26/2025	11:00:00 AM	0.34
11/26/2025	11:15:00 AM	0.34
11/26/2025	11:30:00 AM	0.34
11/26/2025	11:45:00 AM	0.34
11/26/2025	12:00:00 PM	0.34
11/26/2025	12:15:00 PM	0.34
11/26/2025	12:30:00 PM	0.34
11/26/2025	12:45:00 PM	0.34
11/26/2025	1:00:00 PM	0.34
11/26/2025	1:15:00 PM	0.34
11/26/2025	1:30:00 PM	0.34
11/26/2025	1:45:00 PM	0.34
11/26/2025	2:00:00 PM	0.34
11/26/2025	2:15:00 PM	0.34
11/26/2025	2:30:00 PM	0.34
11/26/2025	2:45:00 PM	0.34
11/26/2025	3:00:00 PM	0.34
11/26/2025	3:15:00 PM	0.34
11/26/2025	3:30:00 PM	0.34
11/26/2025	3:45:00 PM	0.34
11/26/2025	4:00:00 PM	0.34
11/26/2025	4:15:00 PM	0.34
11/26/2025	4:30:00 PM	0.34
11/26/2025	4:45:00 PM	0.34
11/26/2025	5:00:00 PM	0.34
11/26/2025	5:15:00 PM	0.34
11/26/2025	5:30:00 PM	0.34
11/26/2025	5:45:00 PM	0.34
11/26/2025	6:00:00 PM	0.34
11/26/2025	6:15:00 PM	0.34
11/26/2025	6:30:00 PM	0.34
11/26/2025	6:45:00 PM	0.34
11/26/2025	7:00:00 PM	0.34
11/26/2025	7:15:00 PM	0.34
11/26/2025	7:30:00 PM	0.34
11/26/2025	7:45:00 PM	0.34
11/26/2025	8:00:00 PM	0.34
11/26/2025	8:15:00 PM	0.34
11/26/2025	8:30:00 PM	0.34
11/26/2025	8:45:00 PM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/26/2025	9:00:00 PM	0.34
11/26/2025	9:15:00 PM	0.34
11/26/2025	9:30:00 PM	0.34
11/26/2025	9:45:00 PM	0.34
11/26/2025	10:00:00 PM	0.34
11/26/2025	10:15:00 PM	0.34
11/26/2025	10:30:00 PM	0.34
11/26/2025	10:45:00 PM	0.34
11/26/2025	11:00:00 PM	0.34
11/26/2025	11:15:00 PM	0.34
11/26/2025	11:30:00 PM	0.34
11/26/2025	11:45:00 PM	0.34
11/27/2025	12:00:00 AM	0.34
11/27/2025	12:15:00 AM	0.34
11/27/2025	12:30:00 AM	0.34
11/27/2025	12:45:00 AM	0.34
11/27/2025	1:00:00 AM	0.34
11/27/2025	1:15:00 AM	0.34
11/27/2025	1:30:00 AM	0.34
11/27/2025	1:45:00 AM	0.34
11/27/2025	2:00:00 AM	0.34
11/27/2025	2:15:00 AM	0.34
11/27/2025	2:30:00 AM	0.34
11/27/2025	2:45:00 AM	0.34
11/27/2025	3:00:00 AM	0.34
11/27/2025	3:15:00 AM	0.34
11/27/2025	3:30:00 AM	0.34
11/27/2025	3:45:00 AM	0.34
11/27/2025	4:00:00 AM	0.34
11/27/2025	4:15:00 AM	0.34
11/27/2025	4:30:00 AM	0.34
11/27/2025	4:45:00 AM	0.34
11/27/2025	5:00:00 AM	0.34
11/27/2025	5:15:00 AM	0.34
11/27/2025	5:30:00 AM	0.34
11/27/2025	5:45:00 AM	0.34
11/27/2025	6:00:00 AM	0.34
11/27/2025	6:15:00 AM	0.34
11/27/2025	6:30:00 AM	0.34
11/27/2025	6:45:00 AM	0.34
11/27/2025	7:00:00 AM	0.34
11/27/2025	7:15:00 AM	0.34
11/27/2025	7:30:00 AM	0.34
11/27/2025	7:45:00 AM	0.34
11/27/2025	8:00:00 AM	0.34
11/27/2025	8:15:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/27/2025	8:30:00 AM	0.34
11/27/2025	8:45:00 AM	0.34
11/27/2025	9:00:00 AM	0.34
11/27/2025	9:15:00 AM	0.34
11/27/2025	9:30:00 AM	0.34
11/27/2025	9:45:00 AM	0.34
11/27/2025	10:00:00 AM	0.34
11/27/2025	10:15:00 AM	0.34
11/27/2025	10:30:00 AM	0.34
11/27/2025	10:45:00 AM	0.34
11/27/2025	11:00:00 AM	0.35
11/27/2025	11:15:00 AM	0.34
11/27/2025	11:30:00 AM	0.34
11/27/2025	11:45:00 AM	0.34
11/27/2025	12:00:00 PM	0.34
11/27/2025	12:15:00 PM	0.34
11/27/2025	12:30:00 PM	0.34
11/27/2025	12:45:00 PM	0.34
11/27/2025	1:00:00 PM	0.34
11/27/2025	1:15:00 PM	0.34
11/27/2025	1:30:00 PM	0.34
11/27/2025	1:45:00 PM	0.34
11/27/2025	2:00:00 PM	0.34
11/27/2025	2:15:00 PM	0.34
11/27/2025	2:30:00 PM	0.34
11/27/2025	2:45:00 PM	0.34
11/27/2025	3:00:00 PM	0.34
11/27/2025	3:15:00 PM	0.34
11/27/2025	3:30:00 PM	0.34
11/27/2025	3:45:00 PM	0.34
11/27/2025	4:00:00 PM	0.34
11/27/2025	4:15:00 PM	0.34
11/27/2025	4:30:00 PM	0.34
11/27/2025	4:45:00 PM	0.34
11/27/2025	5:00:00 PM	0.34
11/27/2025	5:15:00 PM	0.34
11/27/2025	5:30:00 PM	0.34
11/27/2025	5:45:00 PM	0.34
11/27/2025	6:00:00 PM	0.34
11/27/2025	6:15:00 PM	0.34
11/27/2025	6:30:00 PM	0.34
11/27/2025	6:45:00 PM	0.34
11/27/2025	7:00:00 PM	0.34
11/27/2025	7:15:00 PM	0.34
11/27/2025	7:30:00 PM	0.34
11/27/2025	7:45:00 PM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/27/2025	8:00:00 PM	0.34
11/27/2025	8:15:00 PM	0.34
11/27/2025	8:30:00 PM	0.34
11/27/2025	8:45:00 PM	0.34
11/27/2025	9:00:00 PM	0.34
11/27/2025	9:15:00 PM	0.34
11/27/2025	9:30:00 PM	0.34
11/27/2025	9:45:00 PM	0.34
11/27/2025	10:00:00 PM	0.34
11/27/2025	10:15:00 PM	0.34
11/27/2025	10:30:00 PM	0.34
11/27/2025	10:45:00 PM	0.34
11/27/2025	11:00:00 PM	0.34
11/27/2025	11:15:00 PM	0.34
11/27/2025	11:30:00 PM	0.34
11/27/2025	11:45:00 PM	0.34
11/28/2025	12:00:00 AM	0.34
11/28/2025	12:15:00 AM	0.34
11/28/2025	12:30:00 AM	0.34
11/28/2025	12:45:00 AM	0.34
11/28/2025	1:00:00 AM	0.34
11/28/2025	1:15:00 AM	0.34
11/28/2025	1:30:00 AM	0.34
11/28/2025	1:45:00 AM	0.34
11/28/2025	2:00:00 AM	0.34
11/28/2025	2:15:00 AM	0.34
11/28/2025	2:30:00 AM	0.34
11/28/2025	2:45:00 AM	0.34
11/28/2025	3:00:00 AM	0.34
11/28/2025	3:15:00 AM	0.34
11/28/2025	3:30:00 AM	0.34
11/28/2025	3:45:00 AM	0.34
11/28/2025	4:00:00 AM	0.34
11/28/2025	4:15:00 AM	0.34
11/28/2025	4:30:00 AM	0.34
11/28/2025	4:45:00 AM	0.34
11/28/2025	5:00:00 AM	0.34
11/28/2025	5:15:00 AM	0.34
11/28/2025	5:30:00 AM	0.34
11/28/2025	5:45:00 AM	0.34
11/28/2025	6:00:00 AM	0.34
11/28/2025	6:15:00 AM	0.34
11/28/2025	6:30:00 AM	0.34
11/28/2025	6:45:00 AM	0.34
11/28/2025	7:00:00 AM	0.34
11/28/2025	7:15:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/28/2025	7:30:00 AM	0.34
11/28/2025	7:45:00 AM	0.34
11/28/2025	8:00:00 AM	0.34
11/28/2025	8:15:00 AM	0.34
11/28/2025	8:30:00 AM	0.34
11/28/2025	8:45:00 AM	0.34
11/28/2025	9:00:00 AM	0.34
11/28/2025	9:15:00 AM	0.34
11/28/2025	9:30:00 AM	0.34
11/28/2025	9:45:00 AM	0.34
11/28/2025	10:00:00 AM	0.34
11/28/2025	10:15:00 AM	0.34
11/28/2025	10:30:00 AM	0.34
11/28/2025	10:45:00 AM	0.34
11/28/2025	11:00:00 AM	0.34
11/28/2025	11:15:00 AM	0.34
11/28/2025	11:30:00 AM	0.34
11/28/2025	11:45:00 AM	0.34
11/28/2025	12:00:00 PM	0.34
11/28/2025	12:15:00 PM	0.34
11/28/2025	12:30:00 PM	0.34
11/28/2025	12:45:00 PM	0.34
11/28/2025	1:00:00 PM	0.34
11/28/2025	1:15:00 PM	0.34
11/28/2025	1:30:00 PM	0.34
11/28/2025	1:45:00 PM	0.34
11/28/2025	2:00:00 PM	0.34
11/28/2025	2:15:00 PM	0.34
11/28/2025	2:30:00 PM	0.34
11/28/2025	2:45:00 PM	0.34
11/28/2025	3:00:00 PM	0.34
11/28/2025	3:15:00 PM	0.34
11/28/2025	3:30:00 PM	0.34
11/28/2025	3:45:00 PM	0.34
11/28/2025	4:00:00 PM	0.34
11/28/2025	4:15:00 PM	0.34
11/28/2025	4:30:00 PM	0.34
11/28/2025	4:45:00 PM	0.34
11/28/2025	5:00:00 PM	0.34
11/28/2025	5:15:00 PM	0.34
11/28/2025	5:30:00 PM	0.34
11/28/2025	5:45:00 PM	0.34
11/28/2025	6:00:00 PM	0.34
11/28/2025	6:15:00 PM	0.34
11/28/2025	6:30:00 PM	0.34
11/28/2025	6:45:00 PM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/28/2025	7:00:00 PM	0.34
11/28/2025	7:15:00 PM	0.34
11/28/2025	7:30:00 PM	0.34
11/28/2025	7:45:00 PM	0.34
11/28/2025	8:00:00 PM	0.34
11/28/2025	8:15:00 PM	0.34
11/28/2025	8:30:00 PM	0.34
11/28/2025	8:45:00 PM	0.34
11/28/2025	9:00:00 PM	0.34
11/28/2025	9:15:00 PM	0.34
11/28/2025	9:30:00 PM	0.34
11/28/2025	9:45:00 PM	0.34
11/28/2025	10:00:00 PM	0.34
11/28/2025	10:15:00 PM	0.34
11/28/2025	10:30:00 PM	0.34
11/28/2025	10:45:00 PM	0.34
11/28/2025	11:00:00 PM	0.34
11/28/2025	11:15:00 PM	0.34
11/28/2025	11:30:00 PM	0.34
11/28/2025	11:45:00 PM	0.34
11/29/2025	12:00:00 AM	0.34
11/29/2025	12:15:00 AM	0.34
11/29/2025	12:30:00 AM	0.34
11/29/2025	12:45:00 AM	0.34
11/29/2025	1:00:00 AM	0.34
11/29/2025	1:15:00 AM	0.34
11/29/2025	1:30:00 AM	0.34
11/29/2025	1:45:00 AM	0.34
11/29/2025	2:00:00 AM	0.34
11/29/2025	2:15:00 AM	0.34
11/29/2025	2:30:00 AM	0.34
11/29/2025	2:45:00 AM	0.34
11/29/2025	3:00:00 AM	0.34
11/29/2025	3:15:00 AM	0.34
11/29/2025	3:30:00 AM	0.34
11/29/2025	3:45:00 AM	0.34
11/29/2025	4:00:00 AM	0.34
11/29/2025	4:15:00 AM	0.34
11/29/2025	4:30:00 AM	0.34
11/29/2025	4:45:00 AM	0.34
11/29/2025	5:00:00 AM	0.34
11/29/2025	5:15:00 AM	0.34
11/29/2025	5:30:00 AM	0.34
11/29/2025	5:45:00 AM	0.34
11/29/2025	6:00:00 AM	0.34
11/29/2025	6:15:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/29/2025	6:30:00 AM	0.34
11/29/2025	6:45:00 AM	0.34
11/29/2025	7:00:00 AM	0.34
11/29/2025	7:15:00 AM	0.34
11/29/2025	7:30:00 AM	0.34
11/29/2025	7:45:00 AM	0.34
11/29/2025	8:00:00 AM	0.34
11/29/2025	8:15:00 AM	0.34
11/29/2025	8:30:00 AM	0.34
11/29/2025	8:45:00 AM	0.34
11/29/2025	9:00:00 AM	0.34
11/29/2025	9:15:00 AM	0.34
11/29/2025	9:30:00 AM	0.34
11/29/2025	9:45:00 AM	0.34
11/29/2025	10:00:00 AM	0.34
11/29/2025	10:15:00 AM	0.34
11/29/2025	10:30:00 AM	0.34
11/29/2025	10:45:00 AM	0.34
11/29/2025	11:00:00 AM	0.34
11/29/2025	11:15:00 AM	0.34
11/29/2025	11:30:00 AM	0.36
11/29/2025	11:45:00 AM	0.36
11/29/2025	12:00:00 PM	0.36
11/29/2025	12:15:00 PM	0.36
11/29/2025	12:30:00 PM	0.36
11/29/2025	12:45:00 PM	0.36
11/29/2025	1:00:00 PM	0.36
11/29/2025	1:15:00 PM	0.36
11/29/2025	1:30:00 PM	0.36
11/29/2025	1:45:00 PM	0.36
11/29/2025	2:00:00 PM	0.36
11/29/2025	2:15:00 PM	0.36
11/29/2025	2:30:00 PM	0.35
11/29/2025	2:45:00 PM	0.35
11/29/2025	3:00:00 PM	0.35
11/29/2025	3:15:00 PM	0.35
11/29/2025	3:30:00 PM	0.35
11/29/2025	3:45:00 PM	0.35
11/29/2025	4:00:00 PM	0.35
11/29/2025	4:15:00 PM	0.35
11/29/2025	4:30:00 PM	0.35
11/29/2025	4:45:00 PM	0.35
11/29/2025	5:00:00 PM	0.35
11/29/2025	5:15:00 PM	0.35
11/29/2025	5:30:00 PM	0.35
11/29/2025	5:45:00 PM	0.35

Billy Lake Return Gage

DATE	TIME	GAGE
11/29/2025	6:00:00 PM	0.35
11/29/2025	6:15:00 PM	0.35
11/29/2025	6:30:00 PM	0.35
11/29/2025	6:45:00 PM	0.35
11/29/2025	7:00:00 PM	0.35
11/29/2025	7:15:00 PM	0.35
11/29/2025	7:30:00 PM	0.34
11/29/2025	7:45:00 PM	0.34
11/29/2025	8:00:00 PM	0.34
11/29/2025	8:15:00 PM	0.34
11/29/2025	8:30:00 PM	0.34
11/29/2025	8:45:00 PM	0.34
11/29/2025	9:00:00 PM	0.34
11/29/2025	9:15:00 PM	0.34
11/29/2025	9:30:00 PM	0.34
11/29/2025	9:45:00 PM	0.34
11/29/2025	10:00:00 PM	0.34
11/29/2025	10:15:00 PM	0.34
11/29/2025	10:30:00 PM	0.34
11/29/2025	10:45:00 PM	0.34
11/29/2025	11:00:00 PM	0.34
11/29/2025	11:15:00 PM	0.34
11/29/2025	11:30:00 PM	0.34
11/29/2025	11:45:00 PM	0.34
11/30/2025	12:00:00 AM	0.34
11/30/2025	12:15:00 AM	0.34
11/30/2025	12:30:00 AM	0.34
11/30/2025	12:45:00 AM	0.34
11/30/2025	1:00:00 AM	0.34
11/30/2025	1:15:00 AM	0.34
11/30/2025	1:30:00 AM	0.34
11/30/2025	1:45:00 AM	0.34
11/30/2025	2:00:00 AM	0.34
11/30/2025	2:15:00 AM	0.34
11/30/2025	2:30:00 AM	0.34
11/30/2025	2:45:00 AM	0.34
11/30/2025	3:00:00 AM	0.34
11/30/2025	3:15:00 AM	0.34
11/30/2025	3:30:00 AM	0.34
11/30/2025	3:45:00 AM	0.34
11/30/2025	4:00:00 AM	0.34
11/30/2025	4:15:00 AM	0.34
11/30/2025	4:30:00 AM	0.34
11/30/2025	4:45:00 AM	0.34
11/30/2025	5:00:00 AM	0.34
11/30/2025	5:15:00 AM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/30/2025	5:30:00 AM	0.34
11/30/2025	5:45:00 AM	0.34
11/30/2025	6:00:00 AM	0.34
11/30/2025	6:15:00 AM	0.34
11/30/2025	6:30:00 AM	0.34
11/30/2025	6:45:00 AM	0.34
11/30/2025	7:00:00 AM	0.34
11/30/2025	7:15:00 AM	0.34
11/30/2025	7:30:00 AM	0.34
11/30/2025	7:45:00 AM	0.34
11/30/2025	8:00:00 AM	0.34
11/30/2025	8:15:00 AM	0.34
11/30/2025	8:30:00 AM	0.34
11/30/2025	8:45:00 AM	0.34
11/30/2025	9:00:00 AM	0.34
11/30/2025	9:15:00 AM	0.34
11/30/2025	9:30:00 AM	0.34
11/30/2025	9:45:00 AM	0.34
11/30/2025	10:00:00 AM	0.34
11/30/2025	10:15:00 AM	0.34
11/30/2025	10:30:00 AM	0.34
11/30/2025	10:45:00 AM	0.34
11/30/2025	11:00:00 AM	0.34
11/30/2025	11:15:00 AM	0.34
11/30/2025	11:30:00 AM	0.34
11/30/2025	11:45:00 AM	0.34
11/30/2025	12:00:00 PM	0.34
11/30/2025	12:15:00 PM	0.34
11/30/2025	12:30:00 PM	0.34
11/30/2025	12:45:00 PM	0.34
11/30/2025	1:00:00 PM	0.34
11/30/2025	1:15:00 PM	0.34
11/30/2025	1:30:00 PM	0.34
11/30/2025	1:45:00 PM	0.34
11/30/2025	2:00:00 PM	0.34
11/30/2025	2:15:00 PM	0.34
11/30/2025	2:30:00 PM	0.34
11/30/2025	2:45:00 PM	0.34
11/30/2025	3:00:00 PM	0.34
11/30/2025	3:15:00 PM	0.34
11/30/2025	3:30:00 PM	0.34
11/30/2025	3:45:00 PM	0.34
11/30/2025	4:00:00 PM	0.34
11/30/2025	4:15:00 PM	0.34
11/30/2025	4:30:00 PM	0.34
11/30/2025	4:45:00 PM	0.34

Billy Lake Return Gage

DATE	TIME	GAGE
11/30/2025	5:00:00 PM	0.34
11/30/2025	5:15:00 PM	0.34
11/30/2025	5:30:00 PM	0.34
11/30/2025	5:45:00 PM	0.34
11/30/2025	6:00:00 PM	0.34
11/30/2025	6:15:00 PM	0.34
11/30/2025	6:30:00 PM	0.34
11/30/2025	6:45:00 PM	0.34
11/30/2025	7:00:00 PM	0.34
11/30/2025	7:15:00 PM	0.34
11/30/2025	7:30:00 PM	0.34
11/30/2025	7:45:00 PM	0.34
11/30/2025	8:00:00 PM	0.34
11/30/2025	8:15:00 PM	0.34
11/30/2025	8:30:00 PM	0.34
11/30/2025	8:45:00 PM	0.34
11/30/2025	9:00:00 PM	0.34
11/30/2025	9:15:00 PM	0.34
11/30/2025	9:30:00 PM	0.34
11/30/2025	9:45:00 PM	0.34
11/30/2025	10:00:00 PM	0.34
11/30/2025	10:15:00 PM	0.34
11/30/2025	10:30:00 PM	0.34
11/30/2025	10:45:00 PM	0.34
11/30/2025	11:00:00 PM	0.34
11/30/2025	11:15:00 PM	0.34
11/30/2025	11:30:00 PM	0.34
11/30/2025	11:45:00 PM	0.34

Party: BLP / BJA	Width: 21.6 ft	Processed by: BJA
Boat/Motor: BOAT	Area: 68.2 ft ²	Mean Velocity: 0.714 ft/s
Gage Height: 3.37 ft	G.H.Change: 0.000 ft	Discharge: 48.6 ft ³ /s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.00°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft ²	Diff.: 0.000%
Depth: Composite (BT)	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:		ADCP:	
BT 3-Beam Solution: YES	Max. Vel.: 1.34 ft/s	Type/Freq.: StreamPro / 2000 kHz	
WT 3-Beam Solution: YES	Max. Depth: 3.56 ft	Serial #: 2370	Firmware: 31.17
BT Error Vel.: 0.33 ft/s	Mean Depth: 3.15 ft	Bin Size: 17 cm	Blank: 3 cm
WT Error Vel.: 0.98 ft/s	% Meas.: 47.39	BT Mode: 10	BT Pings: 2
BT Up Vel.: 1.00 ft/s	Water Temp.: None	WT Mode: 12	WT Pings: 6
WT Up Vel.: 1.64 ft/s	ADCP Temp.: 63.2 °F		
Use Weighted Mean Depth: YES			

Performed Diag. Test: YES
 Performed Moving Bed Test: NO
 Performed Compass Calibration: NO Evaluation: NO
 Meas. Location: BRIDGE

Project Name: 251202 LOR @ MAZOURKA_0
 Software: 2.26.00.04

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
001	R	2	2	33	9.39	21.5	11.6	1.77	1.62	45.9	22	69	11:14	11:15	0.48	0.67	0	0
002	L	2	2	35	10.6	24.2	12.6	1.59	1.77	50.7	22	68	11:15	11:16	0.45	0.75	0	0
003	R	2	2	32	10.1	23.1	12.3	1.66	1.62	48.8	22	69	11:16	11:17	0.51	0.71	0	0
004	L	2	2	32	9.92	22.7	11.9	1.70	1.59	47.8	22	69	11:17	11:18	0.50	0.70	0	0
005	R	2	2	34	10.3	23.7	12.4	1.94	1.62	49.9	21	67	11:18	11:19	0.48	0.74	0	0
Mean		2	2	33	10.1	23.1	12.2	1.73	1.65	48.6	22	68	Total	00:04	0.48	0.71	0	0
SDev		0	0	1	0.441	1.02	0.424	0.134	0.069	1.88	0.2	0.7			0.02	0.04		
SD/M		0.0%	0.0%	4.0%	4.4%	4.4%	3.5%	7.8%	4.2%	3.9%	0.8%	1.1%			4.2%	4.9%		

Remarks:

Discharge for transects in *italics* have a total Q more than 5% from the mean

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	1	0	0	0	26.8	-1.7	0.943	0.5	0.4	0	47.3	51.6	0	138	147	0	28	27
2025	11	1	0	10	0	27	-2.1	0.943	0.4	0.3	0	48.2	52	0	139	148	0	27	27
2025	11	1	0	20	0	25.2	-0.4	0.943	0.4	0.3	0	48.2	46.4	0	139	136	0	27	28
2025	11	1	0	30	0	27.5	-2.4	0.943	0.5	0.4	0	47.7	52	0	138	148	0	27	27
2025	11	1	0	40	0	25.7	-2.2	0.943	0.5	0.5	0	47.3	51.6	0	138	148	0	28	28
2025	11	1	0	50	0	27.1	-2	0.943	0.4	0.3	0	47.3	51.2	0	137	148	0	27	29
2025	11	1	1	0	0	26.7	-1.6	0.943	0.5	0.4	0	47.7	51.6	0	138	148	0	27	28
2025	11	1	1	10	0	26.2	-2.5	0.943	0.5	0.4	0	47.3	51.6	0	138	148	0	28	28
2025	11	1	1	20	0	27.9	-2.3	0.943	0.5	0.5	0	47.3	50.7	0	137	147	0	27	29
2025	11	1	1	30	0	27	-1.6	0.943	0.5	0.4	0	46.9	51.6	0	137	148	0	28	28
2025	11	1	1	40	0	27	-1.7	0.943	0.5	0.4	0	46.9	51.2	0	137	147	0	28	28
2025	11	1	1	50	0	27.9	-1.7	0.943	0.3	0.2	0	46.9	51.2	0	137	147	0	28	28
2025	11	1	2	0	0	26.1	-1.7	0.943	0.4	0.3	0	46.9	51.2	0	137	147	0	28	28
2025	11	1	2	10	0	26.7	-2	0.943	0.5	0.4	0	46.4	51.2	0	136	147	0	28	28
2025	11	1	2	20	0	26.7	-1.3	0.943	0.3	0.2	0	46.9	51.2	0	136	147	0	27	28
2025	11	1	2	30	0	26.6	-1.4	0.943	0.5	0.4	0	46.4	51.6	0	136	147	0	28	27
2025	11	1	2	40	0	27.4	-1.9	0.943	0.5	0.5	0	46.9	51.2	0	137	147	0	28	28
2025	11	1	2	50	0	27.2	-1.8	0.943	0.4	0.3	0	46.4	51.2	0	136	147	0	28	28
2025	11	1	3	0	0	26.1	-2	0.942	0.4	0.3	0	46.4	51.2	0	136	147	0	28	28
2025	11	1	3	10	0	26	-2.1	0.943	0.5	0.4	0	46.9	51.2	0	136	147	0	27	28
2025	11	1	3	20	0	26.2	-1.5	0.943	0.4	0.3	0	46.4	51.2	0	136	147	0	28	28
2025	11	1	3	30	0	25.8	-0.9	0.943	0.5	0.5	0	46.9	51.2	0	136	147	0	27	28
2025	11	1	3	40	0	27.1	-1.7	0.943	0.4	0.3	0	46.4	51.2	0	135	147	0	27	28
2025	11	1	3	50	0	26.2	-1.3	0.943	0.5	0.5	0	46.4	51.2	0	136	147	0	28	28
2025	11	1	4	0	0	26.5	-1.7	0.943	0.4	0.3	0	47.3	51.6	0	137	148	0	27	28
2025	11	1	4	10	0	26.5	-2.8	0.943	0.6	0.5	0	46.9	51.2	0	136	147	0	27	28
2025	11	1	4	20	0	26.6	-1.9	0.943	0.4	0.3	0	46.9	51.6	0	136	147	0	27	27
2025	11	1	4	30	0	26.7	-2.1	0.943	0.4	0.3	0	46	51.2	0	135	147	0	28	28
2025	11	1	4	40	0	26.8	-1.9	0.943	0.5	0.4	0	46.4	51.2	0	135	147	0	27	28
2025	11	1	4	50	0	27	-1.8	0.943	0.5	0.4	0	46	50.7	0	135	146	0	28	28
2025	11	1	5	0	0	27.1	-1.9	0.943	0.3	0.2	0	45.6	51.2	0	135	147	0	29	28
2025	11	1	5	10	0	26.8	-2.4	0.943	0.6	0.5	0	46	51.2	0	135	147	0	28	28
2025	11	1	5	20	0	27.1	-2.4	0.943	0.4	0.3	0	46	51.2	0	135	147	0	28	28
2025	11	1	5	30	0	25.6	-3.5	0.943	0.5	0.4	0	46.4	50.7	0	135	146	0	27	28
2025	11	1	5	40	0	27.7	-1.4	0.943	0.5	0.4	0	46	51.2	0	135	147	0	28	28
2025	11	1	5	50	0	27.8	-2.5	0.943	0.5	0.4	0	46.4	51.2	0	135	147	0	27	28
2025	11	1	6	0	0	26.9	-2.5	0.943	0.4	0.3	0	46.4	51.2	0	135	147	0	27	28
2025	11	1	6	10	0	26.6	-3.2	0.943	0.5	0.4	0	45.6	51.2	0	134	147	0	28	28
2025	11	1	6	20	0	26.1	-1.7	0.943	0.4	0.3	0	46	51.2	0	135	147	0	28	28
2025	11	1	6	30	0	27.4	-2.2	0.944	0.5	0.4	0	46	51.2	0	135	147	0	28	28
2025	11	1	6	40	0	27.3	-2.8	0.943	0.5	0.4	0	45.6	51.2	0	134	147	0	28	28
2025	11	1	6	50	0	27.6	-1.7	0.944	0.3	0.2	0	45.6	51.6	0	134	147	0	28	27
2025	11	1	7	0	0	26.7	-1.3	0.944	0.5	0.4	0	46	51.2	0	135	147	0	28	28
2025	11	1	7	10	0	26.7	-1.3	0.945	0.5	0.4	0	46	50.7	0	134	147	0	27	29
2025	11	1	7	20	0	24.9	-1.2	0.944	0.4	0.3	0	45.6	51.2	0	134	147	0	28	28
2025	11	1	7	30	0	26.8	-1.3	0.944	0.3	0.2	0	45.2	50.7	0	133	146	0	28	28
2025	11	1	7	40	0	26.6	-1.7	0.945	0.4	0.3	0	45.2	50.7	0	133	146	0	28	28
2025	11	1	7	50	0	26.4	-2	0.945	0.5	0.4	0	44.7	49.9	0	132	145	0	28	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	1	8	0	0	26.4	-1	0.946	0.5	0.5	0	44.7	50.3	0	132	145	0	28	28
2025	11	1	8	10	0	26.5	-1.7	0.945	0.5	0.4	0	44.3	49.9	0	131	144	0	28	28
2025	11	1	8	20	0	26.2	-1.8	0.945	0.5	0.5	0	45.2	49.9	0	132	144	0	27	28
2025	11	1	8	30	0	26	-2.8	0.945	0.5	0.4	0	44.7	49.5	0	131	144	0	27	29
2025	11	1	8	40	0	26.3	-1.9	0.945	0.4	0.3	0	44.7	49.9	0	131	144	0	27	28
2025	11	1	8	50	0	26.4	-1.9	0.945	0.5	0.4	0	43.9	49	0	130	143	0	28	29
2025	11	1	9	0	0	26.1	-3	0.945	0.5	0.5	0	43.4	49	0	129	142	0	28	28
2025	11	1	9	10	0	25	-2.1	0.945	0.5	0.4	0	43.9	49	0	130	142	0	28	28
2025	11	1	9	20	0	26.6	-2.9	0.945	0.4	0.3	0	43.4	49	0	129	142	0	28	28
2025	11	1	9	30	0	25.6	-2.1	0.944	0.5	0.4	0	44.3	49.5	0	131	143	0	28	28
2025	11	1	9	40	0	25.6	-0.7	0.944	0.5	0.4	0	44.7	49.9	0	132	145	0	28	29
2025	11	1	9	50	0	25.8	-2.5	0.945	0.5	0.4	0	44.7	49.5	0	132	144	0	28	29
2025	11	1	10	0	0	26	-3	0.945	0.5	0.4	0	44.3	49.5	0	131	143	0	28	28
2025	11	1	10	10	0	26.9	-2.2	0.945	0.4	0.3	0	43.4	48.6	0	129	142	0	28	29
2025	11	1	10	20	0	26.4	-1.5	0.944	0.5	0.4	0	44.7	50.3	0	132	145	0	28	28
2025	11	1	10	30	0	25.9	-2.1	0.944	0.4	0.3	0	45.6	50.7	0	134	146	0	28	28
2025	11	1	10	40	0	26.6	-2.2	0.944	0.5	0.5	0	44.7	49.9	0	132	144	0	28	28
2025	11	1	10	50	0	27.1	-2.7	0.943	0.4	0.3	0	44.3	49.5	0	131	143	0	28	28
2025	11	1	11	0	0	26.3	-1.7	0.943	0.5	0.4	0	43.9	49.5	0	130	143	0	28	28
2025	11	1	11	10	0	26.8	-2.1	0.943	0.5	0.4	0	43.9	49.5	0	129	142	0	27	27
2025	11	1	11	20	0	26.2	-1.3	0.943	0.5	0.4	0	42.6	48.2	0	127	140	0	28	28
2025	11	1	11	30	0	25.8	-2.9	0.943	0.4	0.3	0	43	48.6	0	128	141	0	28	28
2025	11	1	11	40	0	27	-1.8	0.943	0.5	0.4	0	43.4	48.6	0	129	141	0	28	28
2025	11	1	11	50	0	27.1	-2.4	0.943	0.4	0.3	0	43.9	48.6	0	130	142	0	28	29
2025	11	1	12	0	0	26.9	-2.3	0.943	0.4	0.3	0	43.4	49	0	129	142	0	28	28
2025	11	1	12	10	0	25.5	-2.1	0.943	0.5	0.4	0	43.9	49.5	0	130	143	0	28	28
2025	11	1	12	20	0	26.1	-3	0.943	0.5	0.4	0	43.4	48.6	0	129	141	0	28	28
2025	11	1	12	30	0	26.2	-2.5	0.943	0.5	0.4	0	43.9	49	0	130	142	0	28	28
2025	11	1	12	40	0	26.8	-2.2	0.943	0.4	0.3	0	45.2	50.7	0	133	145	0	28	27
2025	11	1	12	50	0	26.4	-2.3	0.943	0.5	0.4	0	44.7	49.9	0	132	145	0	28	29
2025	11	1	13	0	0	25.5	-2.4	0.943	0.5	0.5	0	45.2	50.3	0	133	145	0	28	28
2025	11	1	13	10	0	26.3	-2.8	0.943	0.4	0.3	0	45.2	49.9	0	132	144	0	27	28
2025	11	1	13	20	0	26.7	-2.9	0.944	0.5	0.5	0	43.4	49	0	129	142	0	28	28
2025	11	1	13	30	0	27.2	-3.2	0.943	0.5	0.4	0	44.3	49	0	130	142	0	27	28
2025	11	1	13	40	0	25	-1.7	0.944	0.5	0.4	0	43.9	49	0	129	142	0	27	28
2025	11	1	13	50	0	26.5	-2	0.944	0.4	0.3	0	43.9	49	0	129	141	0	27	27
2025	11	1	14	0	0	25.9	-2.4	0.944	0.4	0.3	0	43.4	48.6	0	129	141	0	28	28
2025	11	1	14	10	0	26.4	-2.6	0.944	0.4	0.3	0	43.9	48.6	0	129	141	0	27	28
2025	11	1	14	20	0	27.4	-2.7	0.943	0.4	0.3	0	43	47.7	0	127	139	0	27	28
2025	11	1	14	30	0	25.3	-2.2	0.944	0.5	0.5	0	43	48.2	0	128	140	0	28	28
2025	11	1	14	40	0	27.3	-2	0.944	0.5	0.5	0	42.6	48.2	0	127	140	0	28	28
2025	11	1	14	50	0	27.3	-1.8	0.943	0.4	0.3	0	43.4	48.6	0	128	141	0	27	28
2025	11	1	15	0	0	26.8	-1.7	0.943	0.4	0.3	0	43.9	49	0	130	142	0	28	28
2025	11	1	15	10	0	27	-2	0.944	0.4	0.3	0	43.4	48.6	0	128	140	0	27	27
2025	11	1	15	20	0	26.2	-2.3	0.944	0.4	0.3	0	42.6	47.7	0	126	139	0	27	28
2025	11	1	15	30	0	26.2	-2.4	0.944	0.3	0.2	0	42.6	48.6	0	127	140	0	28	27
2025	11	1	15	40	0	27	-2.3	0.944	0.4	0.3	0	43	48.2	0	127	140	0	27	28
2025	11	1	15	50	0	25.7	-2	0.944	0.6	0.5	0	43	49	0	128	141	0	28	27

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	1	16	0	0	25.5	-3.1	0.944	0.3	0.2	0	43.4	49	0	128	141	0	27	27
2025	11	1	16	10	0	26.7	-1.9	0.944	0.5	0.4	0	43	48.2	0	127	140	0	27	28
2025	11	1	16	20	0	26	-2.2	0.944	0.4	0.3	0	42.6	48.2	0	127	140	0	28	28
2025	11	1	16	30	0	26.5	-2.2	0.944	0.5	0.4	0	42.6	48.6	0	127	140	0	28	27
2025	11	1	16	40	0	26	-2.5	0.944	0.4	0.3	0	43	48.2	0	127	140	0	27	28
2025	11	1	16	50	0	26.6	-2.4	0.944	0.4	0.3	0	42.6	48.2	0	127	140	0	28	28
2025	11	1	17	0	0	26.2	0	0.944	0.5	0.4	0	43.4	48.6	0	128	141	0	27	28
2025	11	1	17	10	0	26.3	-2	0.944	0.4	0.3	0	43	48.6	0	127	141	0	27	28
2025	11	1	17	20	0	27.1	-1.7	0.944	0.5	0.5	0	42.1	48.2	0	126	140	0	28	28
2025	11	1	17	30	0	27.1	-2.7	0.944	0.5	0.4	0	43	48.2	0	127	140	0	27	28
2025	11	1	17	40	0	26.8	-0.9	0.944	0.5	0.4	0	43	49	0	127	141	0	27	27
2025	11	1	17	50	0	27.6	-2.4	0.944	0.5	0.4	0	43	49	0	127	141	0	27	27
2025	11	1	18	0	0	25.6	-2.4	0.944	0.5	0.4	0	43	48.6	0	127	140	0	27	27
2025	11	1	18	10	0	27	-1	0.944	0.5	0.4	0	43	48.6	0	127	141	0	27	28
2025	11	1	18	20	0	27.2	-1.3	0.945	0.5	0.5	0	43.4	49	0	128	142	0	27	28
2025	11	1	18	30	0	26.6	-1.7	0.945	0.5	0.4	0	43.4	48.6	0	128	141	0	27	28
2025	11	1	18	40	0	26.8	-2.3	0.944	0.6	0.5	0	43.4	49	0	128	143	0	27	29
2025	11	1	18	50	0	27.1	-0.7	0.944	0.5	0.5	0	43.4	49	0	129	142	0	28	28
2025	11	1	19	0	0	26.6	-2.2	0.944	0.4	0.3	0	43.9	49.9	0	129	143	0	27	27
2025	11	1	19	10	0	26.5	-1.5	0.945	0.5	0.4	0	43.4	49.5	0	129	143	0	28	28
2025	11	1	19	20	0	26.7	-1.6	0.944	0.5	0.4	0	43.9	49.5	0	129	143	0	27	28
2025	11	1	19	30	0	26.7	-1.7	0.944	0.5	0.4	0	43.4	49.5	0	129	143	0	28	28
2025	11	1	19	40	0	28.3	-1.5	0.944	0.5	0.4	0	43.9	49.9	0	129	144	0	27	28
2025	11	1	19	50	0	25.9	-1.6	0.944	0.5	0.4	0	43.9	49.9	0	130	144	0	28	28
2025	11	1	20	0	0	27.1	-1.7	0.944	0.5	0.4	0	44.3	50.3	0	130	144	0	27	27
2025	11	1	20	10	0	26.5	-1.8	0.944	0.5	0.4	0	44.3	49.9	0	130	144	0	27	28
2025	11	1	20	20	0	25.7	-1.3	0.944	0.5	0.4	0	43.9	49.9	0	130	144	0	28	28
2025	11	1	20	30	0	27.4	-0.9	0.944	0.5	0.4	0	44.3	49.9	0	130	144	0	27	28
2025	11	1	20	40	0	27.4	-2.6	0.944	0.5	0.4	0	43.9	49.9	0	130	144	0	28	28
2025	11	1	20	50	0	27	-2.1	0.944	0.5	0.5	0	44.3	50.3	0	130	144	0	27	27
2025	11	1	21	0	0	26.6	-3.1	0.944	0.5	0.4	0	44.3	50.7	0	130	145	0	27	27
2025	11	1	21	10	0	27	-1.7	0.944	0.5	0.4	0	43.9	50.3	0	130	145	0	28	28
2025	11	1	21	20	0	26.5	-1.9	0.944	0.5	0.4	0	44.3	50.3	0	130	145	0	27	28
2025	11	1	21	30	0	27.2	-1.7	0.944	0.4	0.3	0	43.9	50.3	0	130	145	0	28	28
2025	11	1	21	40	0	26.8	-2.1	0.944	0.5	0.4	0	43.9	50.3	0	130	145	0	28	28
2025	11	1	21	50	0	26.7	-1.1	0.944	0.5	0.5	0	44.3	50.3	0	130	145	0	27	28
2025	11	1	22	0	0	26.1	-1.4	0.944	0.5	0.4	0	44.3	50.7	0	131	146	0	28	28
2025	11	1	22	10	0	26.4	-1.4	0.944	0.5	0.4	0	44.3	50.7	0	131	146	0	28	28
2025	11	1	22	20	0	25.9	-2.2	0.944	0.5	0.4	0	44.3	50.3	0	131	145	0	28	28
2025	11	1	22	30	0	27.3	-1.7	0.944	0.5	0.5	0	44.7	50.3	0	131	145	0	27	28
2025	11	1	22	40	0	26.1	-2.1	0.944	0.5	0.5	0	44.3	50.7	0	131	146	0	28	28
2025	11	1	22	50	0	25.5	-1.5	0.944	0.4	0.3	0	44.3	50.7	0	131	146	0	28	28
2025	11	1	23	0	0	26.7	-1.3	0.944	0.5	0.4	0	44.3	50.7	0	130	146	0	27	28
2025	11	1	23	10	0	26.1	-1.8	0.944	0.4	0.3	0	44.7	51.2	0	131	146	0	27	27
2025	11	1	23	20	0	27	-1.6	0.944	0.5	0.4	0	44.7	50.7	0	131	146	0	27	28
2025	11	1	23	30	0	26.4	-2	0.944	0.5	0.5	0	44.3	50.7	0	131	146	0	28	28
2025	11	1	23	40	0	25.4	-1.3	0.943	0.4	0.3	0	44.3	51.2	0	130	146	0	27	27
2025	11	1	23	50	0	27	-1.3	0.944	0.5	0.5	0	43.9	50.3	0	130	145	0	28	28

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	2	0	0	0	26.3	-1	0.944	0.5	0.5	0	44.3	50.7	0	130	146	0	27	28
2025	11	2	0	10	0	27.2	-1.6	0.943	0.4	0.3	0	44.3	50.3	0	130	145	0	27	28
2025	11	2	0	20	0	26.7	-2.5	0.943	0.5	0.4	0	44.3	50.3	0	130	145	0	27	28
2025	11	2	0	30	0	26.8	-2.5	0.943	0.4	0.3	0	44.3	49.9	0	130	145	0	27	29
2025	11	2	0	40	0	25.8	-2.4	0.943	0.5	0.4	0	44.3	50.7	0	130	146	0	27	28
2025	11	2	0	50	0	27.3	-2.2	0.943	0.5	0.4	0	43.9	49.9	0	130	145	0	28	29
2025	11	2	1	0	0	27.1	-2.6	0.943	0.5	0.4	0	43.9	50.3	0	130	145	0	28	28
2025	11	2	1	10	0	26.8	-2.1	0.943	0.4	0.3	0	44.3	50.3	0	130	145	0	27	28
2025	11	2	1	20	0	27	-2.1	0.943	0.5	0.4	0	44.3	50.3	0	130	146	0	27	29
2025	11	2	1	30	0	27.2	-1.2	0.943	0.4	0.3	0	43.9	50.7	0	130	146	0	28	28
2025	11	2	1	40	0	26.7	-2.1	0.943	0.5	0.4	0	44.3	50.3	0	130	145	0	27	28
2025	11	2	1	50	0	25.8	-2.1	0.943	0.5	0.4	0	43.9	50.3	0	129	145	0	27	28
2025	11	2	2	0	0	26.7	-1.3	0.943	0.4	0.3	0	43.4	50.3	0	129	145	0	28	28
2025	11	2	2	10	0	26.7	-2.3	0.943	0.4	0.3	0	43.9	50.3	0	129	145	0	27	28
2025	11	2	2	20	0	26.5	-2.5	0.943	0.4	0.3	0	43.4	49.5	0	129	144	0	28	29
2025	11	2	2	30	0	27.4	-1.3	0.943	0.5	0.4	0	43.4	49.9	0	129	144	0	28	28
2025	11	2	2	40	0	25.2	-0.8	0.943	0.5	0.4	0	43.4	50.3	0	130	145	0	29	28
2025	11	2	2	50	0	26.6	-1.6	0.943	0.4	0.3	0	43.4	50.3	0	129	145	0	28	28
2025	11	2	3	0	0	27.4	-1.9	0.943	0.3	0.2	0	43.4	50.3	0	129	145	0	28	28
2025	11	2	3	10	0	26	-1.4	0.943	0.5	0.4	0	43.9	50.3	0	129	144	0	27	27
2025	11	2	3	20	0	26.5	-2.2	0.943	0.4	0.3	0	43.4	50.3	0	129	145	0	28	28
2025	11	2	3	30	0	26.4	-2	0.943	0.4	0.3	0	43.9	49.5	0	129	144	0	27	29
2025	11	2	3	40	0	26.5	-1.2	0.943	0.4	0.3	0	43.4	49.9	0	129	144	0	28	28
2025	11	2	3	50	0	26.9	-2.1	0.943	0.4	0.3	0	43.4	49.9	0	129	144	0	28	28
2025	11	2	4	0	0	26.1	-0.8	0.943	0.3	0.2	0	43.4	49.9	0	129	144	0	28	28
2025	11	2	4	10	0	26.8	-2.4	0.943	0.4	0.3	0	43.9	49.9	0	129	144	0	27	28
2025	11	2	4	20	0	26.3	-1.6	0.942	0.4	0.3	0	43.4	49.9	0	129	144	0	28	28
2025	11	2	4	30	0	26.6	-1.6	0.943	0.5	0.4	0	43.4	49.9	0	129	144	0	28	28
2025	11	2	4	40	0	26.7	-1.5	0.942	0.4	0.3	0	43.9	49.5	0	129	144	0	27	29
2025	11	2	4	50	0	27.2	-1.3	0.943	0.5	0.4	0	43.4	50.3	0	129	145	0	28	28
2025	11	2	5	0	0	26.4	-2.5	0.943	0.4	0.3	0	43.4	49.5	0	129	144	0	28	29
2025	11	2	5	10	0	26.2	-2.6	0.943	0.5	0.4	0	43.4	49.9	0	129	144	0	28	28
2025	11	2	5	20	0	27.8	-2.3	0.943	0.5	0.5	0	43.4	50.3	0	129	145	0	28	28
2025	11	2	5	30	0	26.3	-1.9	0.943	0.5	0.4	0	43.4	50.3	0	129	145	0	28	28
2025	11	2	5	40	0	26.3	-1.9	0.943	0.5	0.4	0	43.4	50.3	0	129	145	0	28	28
2025	11	2	5	50	0	26.9	-1.7	0.943	0.5	0.5	0	43.4	50.3	0	129	145	0	28	28
2025	11	2	6	0	0	26.6	-1.6	0.943	0.5	0.5	0	43.4	50.3	0	129	145	0	28	28
2025	11	2	6	10	0	25.7	-0.8	0.943	0.5	0.4	0	43.4	50.3	0	129	145	0	28	28
2025	11	2	6	20	0	26.8	-2	0.943	0.5	0.5	0	43.4	49.9	0	129	145	0	28	29
2025	11	2	6	30	0	25.6	-1.4	0.944	0.5	0.5	0	43.4	50.3	0	129	145	0	28	28
2025	11	2	6	40	0	26.2	-3.1	0.944	0.3	0.2	0	43.4	50.3	0	129	145	0	28	28
2025	11	2	6	50	0	25.6	-1.7	0.945	0.5	0.4	0	43.4	50.3	0	129	145	0	28	28
2025	11	2	7	0	0	27.5	-2	0.944	0.5	0.4	0	43.9	50.3	0	129	145	0	27	28
2025	11	2	7	10	0	27.4	-2.4	0.944	0.4	0.3	0	43.4	50.3	0	129	145	0	28	28
2025	11	2	7	20	0	26.9	-0.3	0.945	0.5	0.4	0	43	49.5	0	128	144	0	28	29
2025	11	2	7	30	0	26.3	-2.2	0.945	0.5	0.4	0	43	49.9	0	128	144	0	28	28
2025	11	2	7	40	0	26.9	-1.3	0.945	0.5	0.4	0	42.6	49	0	127	143	0	28	29
2025	11	2	7	50	0	26.5	-1.3	0.945	0.5	0.4	0	42.6	49.9	0	127	144	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	2	8	0	0	26.6	-2.7	0.945	0.5	0.4	0	42.6	49.5	0	126	143	0	27	28
2025	11	2	8	10	0	27.1	-2.5	0.946	0.5	0.4	0	41.3	49	0	125	142	0	29	28
2025	11	2	8	20	0	26.2	-0.5	0.945	0.5	0.4	0	42.6	49	0	126	142	0	27	28
2025	11	2	8	30	0	26.2	-0.7	0.946	0.4	0.3	0	42.1	49	0	126	142	0	28	28
2025	11	2	8	40	0	26.8	-1.7	0.946	0.5	0.5	0	41.7	48.2	0	125	141	0	28	29
2025	11	2	8	50	0	26.5	-1.5	0.946	0.5	0.4	0	42.1	48.6	0	125	141	0	27	28
2025	11	2	9	0	0	25.9	-2.6	0.946	0.5	0.4	0	42.1	48.2	0	125	140	0	27	28
2025	11	2	9	10	0	26.8	-1.5	0.946	0.5	0.5	0	41.3	48.2	0	124	139	0	28	27
2025	11	2	9	20	0	27.6	-1.5	0.946	0.5	0.5	0	41.3	47.7	0	123	139	0	27	28
2025	11	2	9	30	0	26.9	-1.9	0.946	0.5	0.4	0	41.3	47.7	0	124	139	0	28	28
2025	11	2	9	40	0	25.7	-1.3	0.946	0.5	0.4	0	40.9	47.3	0	123	138	0	28	28
2025	11	2	9	50	0	26.4	-2.5	0.946	0.5	0.5	0	40.9	47.3	0	123	138	0	28	28
2025	11	2	10	0	0	26.7	-2	0.946	0.6	0.5	0	41.7	48.2	0	125	140	0	28	28
2025	11	2	10	10	0	26	-1.8	0.946	0.5	0.4	0	42.1	49	0	126	141	0	28	27
2025	11	2	10	20	0	26	-0.8	0.946	0.4	0.3	0	42.6	49	0	127	142	0	28	28
2025	11	2	10	30	0	26	-1.6	0.946	0.4	0.3	0	41.3	47.3	0	124	139	0	28	29
2025	11	2	10	40	0	27.3	-1.5	0.946	0.4	0.3	0	41.3	46.9	0	123	137	0	27	28
2025	11	2	10	50	0	26.5	-2.4	0.947	0.5	0.5	0	40.9	47.3	0	123	138	0	28	28
2025	11	2	11	0	0	26.5	-1.7	0.947	0.4	0.3	0	41.7	47.7	0	125	139	0	28	28
2025	11	2	11	10	0	26.2	-2.3	0.946	0.5	0.4	0	40.9	47.3	0	123	138	0	28	28
2025	11	2	11	20	0	26.3	-2.4	0.946	0.5	0.4	0	41.3	47.7	0	124	139	0	28	28
2025	11	2	11	30	0	27.6	-2.7	0.946	0.5	0.4	0	40.4	46.9	0	122	137	0	28	28
2025	11	2	11	40	0	27.6	-1.3	0.946	0.5	0.4	0	40.9	46.9	0	123	138	0	28	29
2025	11	2	11	50	0	26	-2.2	0.946	0.5	0.4	0	40	46.4	0	121	136	0	28	28
2025	11	2	12	0	0	26.8	-2.4	0.946	0.4	0.3	0	40.9	46.9	0	123	138	0	28	29
2025	11	2	12	10	0	26.1	-1.7	0.946	0.5	0.4	0	40.4	46.9	0	122	137	0	28	28
2025	11	2	12	20	0	26.9	-1.8	0.945	0.5	0.4	0	40.4	46.4	0	121	136	0	27	28
2025	11	2	12	30	0	26.6	-1.8	0.945	0.5	0.4	0	40	46.4	0	121	136	0	28	28
2025	11	2	12	40	0	27.5	-1.3	0.945	0.5	0.4	0	40	46.4	0	120	136	0	27	28
2025	11	2	12	50	0	26.8	-1.6	0.944	0.5	0.4	0	40.4	46.4	0	121	136	0	27	28
2025	11	2	13	0	0	26.8	-2.2	0.944	0.3	0.2	0	39.6	46	0	120	135	0	28	28
2025	11	2	13	10	0	26	-1.9	0.944	0.5	0.5	0	40.4	46.4	0	121	136	0	27	28
2025	11	2	13	20	0	26.7	-3	0.944	0.3	0.2	0	40	46.4	0	121	136	0	28	28
2025	11	2	13	30	0	25.7	-2.4	0.944	0.5	0.4	0	40.4	46.4	0	121	136	0	27	28
2025	11	2	13	40	0	26.4	-1.7	0.944	0.5	0.4	0	39.6	46.4	0	120	136	0	28	28
2025	11	2	13	50	0	27.2	-2.1	0.944	0.4	0.3	0	39.6	46	0	120	135	0	28	28
2025	11	2	14	0	0	26.8	-1.3	0.944	0.5	0.4	0	39.1	46	0	119	135	0	28	28
2025	11	2	14	10	0	25.9	-2.7	0.944	0.5	0.4	0	40	46	0	120	135	0	27	28
2025	11	2	14	20	0	26.4	-1.6	0.944	0.5	0.5	0	40.4	46.4	0	121	136	0	27	28
2025	11	2	14	30	0	26.7	-1.9	0.944	0.5	0.4	0	40	46	0	120	135	0	27	28
2025	11	2	14	40	0	25.6	-2.2	0.944	0.5	0.5	0	39.6	46.4	0	120	135	0	28	27
2025	11	2	14	50	0	26.8	-1.7	0.944	0.5	0.4	0	39.6	46.4	0	120	136	0	28	28
2025	11	2	15	0	0	26.3	-2.3	0.944	0.5	0.4	0	39.6	46	0	120	135	0	28	28
2025	11	2	15	10	0	26.7	-1.6	0.945	0.4	0.3	0	40	46	0	120	135	0	27	28
2025	11	2	15	20	0	27.4	-1.7	0.944	0.3	0.2	0	40	46	0	120	135	0	27	28
2025	11	2	15	30	0	27.8	-2	0.944	0.5	0.4	0	40	46.4	0	120	136	0	27	28
2025	11	2	15	40	0	27.3	-2.1	0.944	0.5	0.4	0	40.4	46.4	0	121	136	0	27	28
2025	11	2	15	50	0	26.2	-1.9	0.945	0.5	0.4	0	40.4	47.3	0	122	138	0	28	28

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	2	16	0	0	26.8	-1.7	0.944	0.5	0.4	0	41.7	47.7	0	124	139	0	27	28
2025	11	2	16	10	0	27	-2.7	0.944	0.4	0.3	0	41.3	47.3	0	123	138	0	27	28
2025	11	2	16	20	0	26.7	-2.6	0.944	0.3	0.2	0	40.9	47.7	0	123	139	0	28	28
2025	11	2	16	30	0	27.1	-2.5	0.945	0.4	0.3	0	40.9	47.3	0	122	138	0	27	28
2025	11	2	16	40	0	26.5	-2.5	0.945	0.5	0.5	0	40.9	47.3	0	122	138	0	27	28
2025	11	2	16	50	0	26.3	-2.3	0.944	0.4	0.3	0	41.3	47.7	0	123	139	0	27	28
2025	11	2	17	0	0	27.8	-1.2	0.945	0.5	0.4	0	40.9	47.7	0	123	139	0	28	28
2025	11	2	17	10	0	26.4	-2.1	0.945	0.5	0.4	0	40.9	47.7	0	122	138	0	27	27
2025	11	2	17	20	0	26.8	-1.8	0.945	0.5	0.4	0	40.4	47.7	0	122	139	0	28	28
2025	11	2	17	30	0	27.8	-2.4	0.945	0.5	0.4	0	40.4	47.3	0	122	138	0	28	28
2025	11	2	17	40	0	27.1	-0.7	0.945	0.4	0.3	0	40.4	47.7	0	122	139	0	28	28
2025	11	2	17	50	0	26.6	-1.7	0.945	0.4	0.3	0	40.9	47.7	0	122	139	0	27	28
2025	11	2	18	0	0	27.4	-0.9	0.945	0.3	0.2	0	40.4	47.7	0	122	139	0	28	28
2025	11	2	18	10	0	27.3	-1.8	0.945	0.4	0.3	0	40.9	47.3	0	122	138	0	27	28
2025	11	2	18	20	0	25.4	-1.6	0.945	0.4	0.3	0	40.9	47.7	0	122	139	0	27	28
2025	11	2	18	30	0	26.5	-1.8	0.945	0.4	0.3	0	40.9	47.7	0	123	139	0	28	28
2025	11	2	18	40	0	25.6	-1.7	0.945	0.4	0.3	0	41.7	48.6	0	124	141	0	27	28
2025	11	2	18	50	0	26.8	-1.5	0.945	0.5	0.4	0	41.3	48.6	0	124	141	0	28	28
2025	11	2	19	0	0	26.6	-2.4	0.945	0.5	0.5	0	41.7	48.2	0	124	141	0	27	29
2025	11	2	19	10	0	27	-0.4	0.945	0.5	0.5	0	40.9	48.2	0	123	140	0	28	28
2025	11	2	19	20	0	26.3	-1.3	0.945	0.4	0.3	0	41.7	48.6	0	124	141	0	27	28
2025	11	2	19	30	0	27.1	-2.3	0.945	0.4	0.3	0	41.3	48.6	0	124	141	0	28	28
2025	11	2	19	40	0	26.4	-1.4	0.945	0.5	0.4	0	41.3	48.6	0	123	141	0	27	28
2025	11	2	19	50	0	26.9	-2.1	0.945	0.4	0.3	0	40.9	49	0	123	141	0	28	27
2025	11	2	20	0	0	26.4	-2.2	0.945	0.3	0.2	0	41.3	49	0	124	142	0	28	28
2025	11	2	20	10	0	27.1	-1	0.945	0.5	0.5	0	41.3	49	0	124	142	0	28	28
2025	11	2	20	20	0	27.3	-2.2	0.945	0.4	0.3	0	41.3	48.6	0	123	141	0	27	28
2025	11	2	20	30	0	26.9	-2	0.945	0.4	0.3	0	41.7	49	0	124	142	0	27	28
2025	11	2	20	40	0	27.1	-2	0.945	0.5	0.4	0	41.7	49	0	124	142	0	27	28
2025	11	2	20	50	0	26.4	-1.5	0.945	0.5	0.4	0	41.3	49	0	123	142	0	27	28
2025	11	2	21	0	0	27.5	-2.1	0.945	0.5	0.4	0	41.3	49	0	123	142	0	27	28
2025	11	2	21	10	0	26	-1.4	0.945	0.6	0.5	0	40.9	49	0	123	142	0	28	28
2025	11	2	21	20	0	26.8	-1.5	0.945	0.4	0.3	0	40.9	49.5	0	123	143	0	28	28
2025	11	2	21	30	0	26.6	-2.3	0.945	0.4	0.3	0	40.9	49	0	123	142	0	28	28
2025	11	2	21	40	0	26.8	-2	0.945	0.5	0.4	0	41.7	49.5	0	124	143	0	27	28
2025	11	2	21	50	0	26.7	-1.9	0.945	0.5	0.4	0	41.7	49.5	0	124	143	0	27	28
2025	11	2	22	0	0	26.7	-1.7	0.945	0.4	0.3	0	41.3	49.9	0	123	143	0	27	27
2025	11	2	22	10	0	26.9	-2.1	0.946	0.5	0.5	0	41.7	49.5	0	124	143	0	27	28
2025	11	2	22	20	0	27.3	-1.6	0.946	0.4	0.3	0	41.7	49.5	0	124	143	0	27	28
2025	11	2	22	30	0	27.5	-3	0.946	0.4	0.3	0	41.3	49.9	0	124	143	0	28	27
2025	11	2	22	40	0	25.6	-1.8	0.946	0.5	0.4	0	41.7	49.5	0	124	143	0	27	28
2025	11	2	22	50	0	26.5	-1.1	0.946	0.5	0.5	0	41.3	49.5	0	124	143	0	28	28
2025	11	2	23	0	0	27.1	-1.9	0.947	0.5	0.5	0	41.3	49.5	0	124	144	0	28	29
2025	11	2	23	10	0	27	-0.6	0.947	0.5	0.4	0	41.3	49.5	0	124	143	0	28	28
2025	11	2	23	20	0	26.3	-2	0.947	0.5	0.5	0	40.9	48.6	0	123	142	0	28	29
2025	11	2	23	30	0	26.5	-2.2	0.947	0.5	0.4	0	41.3	49	0	123	143	0	27	29
2025	11	2	23	40	0	26.7	-1.7	0.947	0.5	0.4	0	40.9	49.5	0	123	143	0	28	28
2025	11	2	23	50	0	27.1	-2.1	0.947	0.3	0.2	0	40.9	49.5	0	123	143	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	3	0	0	0	26.9	-2	0.947	0.5	0.4	0	40.9	49.5	0	122	142	0	27	27
2025	11	3	0	10	0	26.1	-1.5	0.947	0.4	0.3	0	40.9	49.5	0	123	143	0	28	28
2025	11	3	0	20	0	26.9	-2.1	0.947	0.4	0.3	0	40.9	49.5	0	122	143	0	27	28
2025	11	3	0	30	0	26.1	-1.7	0.947	0.5	0.5	0	40.4	49.5	0	122	143	0	28	28
2025	11	3	0	40	0	26.3	-0.9	0.947	0.4	0.3	0	40.9	49.5	0	122	143	0	27	28
2025	11	3	0	50	0	26.4	-1.2	0.947	0.3	0.2	0	40.4	49	0	122	143	0	28	29
2025	11	3	1	0	0	25.4	-0.5	0.947	0.5	0.5	0	40	49.5	0	121	143	0	28	28
2025	11	3	1	10	0	26.2	-1.2	0.947	0.4	0.3	0	40	49.5	0	121	143	0	28	28
2025	11	3	1	20	0	27.2	-2.1	0.947	0.5	0.4	0	40	49	0	121	143	0	28	29
2025	11	3	1	30	0	27.7	-2.9	0.947	0.4	0.3	0	40	49.5	0	121	143	0	28	28
2025	11	3	1	40	0	26.5	-1.5	0.947	0.4	0.3	0	40.4	49.9	0	122	143	0	28	27
2025	11	3	1	50	0	26.7	-1.8	0.947	0.4	0.3	0	40.4	49.5	0	121	143	0	27	28
2025	11	3	2	0	0	26.6	-1.6	0.947	0.3	0.2	0	40	49	0	121	142	0	28	28
2025	11	3	2	10	0	26.8	-1.9	0.947	0.5	0.4	0	40	49.5	0	121	143	0	28	28
2025	11	3	2	20	0	26.9	-0.9	0.947	0.3	0.2	0	40	49.5	0	121	143	0	28	28
2025	11	3	2	30	0	27.1	-2.2	0.947	0.5	0.5	0	39.6	49	0	120	142	0	28	28
2025	11	3	2	40	0	26.4	-3.1	0.947	0.5	0.4	0	40	49.5	0	121	143	0	28	28
2025	11	3	2	50	0	26.4	-1.4	0.947	0.5	0.4	0	41.3	49	0	124	142	0	28	28
2025	11	3	3	0	0	26	-2.6	0.947	0.5	0.4	0	41.7	49	0	124	142	0	27	28
2025	11	3	3	10	0	26.3	-2.4	0.947	0.3	0.2	0	40.9	49.5	0	123	142	0	28	27
2025	11	3	3	20	0	26.1	-1.1	0.947	0.4	0.3	0	41.3	49	0	123	142	0	27	28
2025	11	3	3	30	0	26	-1.3	0.947	0.5	0.4	0	41.3	49.5	0	124	143	0	28	28
2025	11	3	3	40	0	25.8	-1.4	0.947	0.5	0.4	0	41.3	49	0	124	142	0	28	28
2025	11	3	3	50	0	27.5	-1.7	0.947	0.5	0.5	0	40.9	48.6	0	123	142	0	28	29
2025	11	3	4	0	0	26.5	-2	0.947	0.3	0.2	0	40.9	49	0	123	142	0	28	28
2025	11	3	4	10	0	26.4	-2.1	0.947	0.5	0.4	0	41.3	49.5	0	123	142	0	27	27
2025	11	3	4	20	0	26	-1.6	0.947	0.6	0.5	0	41.3	49	0	124	142	0	28	28
2025	11	3	4	30	0	26.6	-2.2	0.947	0.5	0.4	0	41.3	49	0	124	142	0	28	28
2025	11	3	4	40	0	27.4	-2.5	0.947	0.4	0.3	0	40.9	48.6	0	123	142	0	28	29
2025	11	3	4	50	0	26.3	-1.6	0.947	0.4	0.3	0	40.9	48.6	0	123	142	0	28	29
2025	11	3	5	0	0	26.3	-2.5	0.947	0.5	0.4	0	40.9	49	0	123	142	0	28	28
2025	11	3	5	10	0	27.8	-1.7	0.947	0.5	0.4	0	40.9	49	0	123	142	0	28	28
2025	11	3	5	20	0	26.4	-2.4	0.947	0.5	0.4	0	40.9	49	0	123	142	0	28	28
2025	11	3	5	30	0	27.2	-2.6	0.947	0.4	0.3	0	41.3	49	0	123	142	0	27	28
2025	11	3	5	40	0	27	-2	0.947	0.5	0.4	0	41.3	49	0	123	142	0	27	28
2025	11	3	5	50	0	26.9	-1.6	0.947	0.4	0.3	0	40.9	49	0	123	142	0	28	28
2025	11	3	6	0	0	28.1	-2.5	0.947	0.5	0.5	0	40.9	49	0	123	142	0	28	28
2025	11	3	6	10	0	26.9	-1.7	0.947	0.4	0.3	0	40.9	48.6	0	123	142	0	28	29
2025	11	3	6	20	0	27.1	-2.2	0.947	0.5	0.4	0	40.9	48.6	0	123	142	0	28	29
2025	11	3	6	30	0	26.3	-2.6	0.947	0.5	0.5	0	40.9	49	0	123	142	0	28	28
2025	11	3	6	40	0	27.1	-2.6	0.947	0.5	0.5	0	41.3	49.5	0	124	143	0	28	28
2025	11	3	6	50	0	25.4	-1.6	0.947	0.4	0.3	0	41.3	49	0	124	143	0	28	29
2025	11	3	7	0	0	26.4	-1.7	0.946	0.4	0.3	0	40.9	49	0	123	142	0	28	28
2025	11	3	7	10	0	26.4	-2.7	0.947	0.5	0.4	0	41.3	49.5	0	124	143	0	28	28
2025	11	3	7	20	0	25.7	-2.8	0.946	0.4	0.3	0	40.9	48.6	0	123	142	0	28	29
2025	11	3	7	30	0	26.4	-3	0.947	0.3	0.2	0	40.9	48.6	0	122	141	0	27	28
2025	11	3	7	40	0	26.1	-1.4	0.946	0.4	0.3	0	40.9	48.2	0	122	141	0	27	29
2025	11	3	7	50	0	27	-2.5	0.947	0.5	0.4	0	40.4	48.2	0	122	141	0	28	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	3	8	0	0	27.1	-3.3	0.947	0.5	0.4	0	40	48.2	0	121	140	0	28	28
2025	11	3	8	10	0	26.5	-1.7	0.947	0.4	0.3	0	40.4	48.2	0	122	140	0	28	28
2025	11	3	8	20	0	26.3	-1.5	0.947	0.4	0.3	0	40	48.2	0	121	140	0	28	28
2025	11	3	8	30	0	25.7	-2.5	0.947	0.5	0.4	0	40.4	48.2	0	122	140	0	28	28
2025	11	3	8	40	0	26.5	-2.3	0.947	0.4	0.3	0	40.4	47.7	0	122	140	0	28	29
2025	11	3	8	50	0	26.1	-2.9	0.947	0.5	0.5	0	40	47.7	0	121	140	0	28	29
2025	11	3	9	0	0	25.7	-2.7	0.947	0.4	0.3	0	39.6	47.3	0	120	138	0	28	28
2025	11	3	9	10	0	26	-2.3	0.947	0.5	0.4	0	39.1	47.3	0	119	138	0	28	28
2025	11	3	9	20	0	26	-2.6	0.947	0.4	0.3	0	38.7	46.9	0	119	137	0	29	28
2025	11	3	9	30	0	25	-2	0.947	0.3	0.2	0	39.1	46.4	0	118	137	0	27	29
2025	11	3	9	40	0	25.1	-2.1	0.947	0.5	0.4	0	38.7	46.4	0	118	136	0	28	28
2025	11	3	9	50	0	25.4	-2.7	0.947	0.5	0.5	0	38.3	46	0	117	135	0	28	28
2025	11	3	10	0	0	27.9	-2.6	0.947	0.4	0.3	0	38.7	46.4	0	118	136	0	28	28
2025	11	3	10	10	0	25.8	-1.7	0.947	0.5	0.4	0	39.1	46.4	0	118	136	0	27	28
2025	11	3	10	20	0	26.1	-2.4	0.947	0.4	0.3	0	38.7	46.4	0	118	136	0	28	28
2025	11	3	10	30	0	25.9	-2.7	0.947	0.5	0.4	0	38.3	46	0	117	136	0	28	29
2025	11	3	10	40	0	25.5	-2.1	0.947	0.5	0.4	0	39.1	46.4	0	119	136	0	28	28
2025	11	3	10	50	0	25	-2.4	0.947	0.5	0.4	0	38.7	46.4	0	118	136	0	28	28
2025	11	3	11	0	0	25.3	-2.5	0.947	0.5	0.5	0	38.3	46	0	117	135	0	28	28
2025	11	3	11	10	0	25.2	-2.8	0.947	0.5	0.4	0	38.3	45.2	0	116	134	0	27	29
2025	11	3	11	20	0	25.6	-1.5	0.947	0.5	0.4	0	38.7	45.6	0	118	135	0	28	29
2025	11	3	11	30	0	25.1	-1.9	0.947	0.3	0.2	0	39.6	47.3	0	120	138	0	28	28
2025	11	3	11	40	0	26.8	-1.7	0.947	0.5	0.4	0	39.6	47.3	0	120	138	0	28	28
2025	11	3	11	50	0	26.5	-3.1	0.947	0.4	0.3	0	38.3	45.6	0	117	134	0	28	28
2025	11	3	12	0	0	26.6	-2.7	0.947	0.4	0.3	0	38.7	46.4	0	118	136	0	28	28
2025	11	3	12	10	0	26.4	-2.3	0.947	0.5	0.4	0	39.6	46.9	0	119	137	0	27	28
2025	11	3	12	20	0	27.3	-1.5	0.947	0.5	0.5	0	39.1	46.9	0	119	137	0	28	28
2025	11	3	12	30	0	26.5	-3.2	0.947	0.4	0.3	0	38.7	46.9	0	118	136	0	28	27
2025	11	3	12	40	0	27.3	-2.4	0.947	0.5	0.4	0	38.7	46	0	117	134	0	27	27
2025	11	3	12	50	0	25.8	-2.2	0.947	0.5	0.4	0	37.4	45.2	0	115	133	0	28	28
2025	11	3	13	0	0	25.7	-2.1	0.947	0.5	0.4	0	37.8	45.2	0	115	133	0	27	28
2025	11	3	13	10	0	26.5	-2.9	0.947	0.5	0.4	0	37.8	44.7	0	115	133	0	27	29
2025	11	3	13	20	0	26.7	-2.7	0.946	0.5	0.4	0	37.8	45.6	0	116	133	0	28	27
2025	11	3	13	30	0	26.5	-2.9	0.946	0.5	0.5	0	38.7	45.6	0	117	134	0	27	28
2025	11	3	13	40	0	27.1	-2.9	0.945	0.6	0.5	0	37.4	44.7	0	116	133	0	29	29
2025	11	3	13	50	0	26.5	-3.7	0.946	0.5	0.5	0	37.8	45.6	0	116	134	0	28	28
2025	11	3	14	0	0	26	-0.9	0.945	0.5	0.4	0	37.8	45.6	0	116	134	0	28	28
2025	11	3	14	10	0	26.5	-2.5	0.945	0.4	0.3	0	37.8	45.2	0	116	133	0	28	28
2025	11	3	14	20	0	26.6	-3.8	0.945	0.4	0.3	0	37.4	45.2	0	115	133	0	28	28
2025	11	3	14	30	0	25.9	-1.7	0.945	0.5	0.4	0	37.8	45.2	0	115	133	0	27	28
2025	11	3	14	40	0	26.5	-2.6	0.945	0.5	0.4	0	37.8	45.6	0	116	134	0	28	28
2025	11	3	14	50	0	25.9	-3.3	0.945	0.5	0.5	0	38.7	46.4	0	117	136	0	27	28
2025	11	3	15	0	0	27	-1.9	0.945	0.5	0.4	0	38.3	46.9	0	117	136	0	28	27
2025	11	3	15	10	0	26.6	-2.3	0.945	0.5	0.4	0	38.7	46	0	118	135	0	28	28
2025	11	3	15	20	0	26.4	-2.2	0.945	0.5	0.4	0	38.7	46.9	0	118	136	0	28	27
2025	11	3	15	30	0	25.7	-1.4	0.945	0.5	0.4	0	39.1	46.4	0	118	136	0	27	28
2025	11	3	15	40	0	26.7	-1.6	0.946	0.5	0.4	0	38.3	46.4	0	117	136	0	28	28
2025	11	3	15	50	0	25.9	-2.6	0.945	0.5	0.4	0	38.3	46	0	117	135	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	3	16	0	0	25.8	-1.5	0.945	0.5	0.4	0	38.3	46	0	117	135	0	28	28
2025	11	3	16	10	0	25.7	-2.2	0.945	0.4	0.3	0	38.7	46.4	0	117	135	0	27	27
2025	11	3	16	20	0	25.9	-1.9	0.945	0.5	0.5	0	38.7	46	0	117	135	0	27	28
2025	11	3	16	30	0	26.8	-3.1	0.944	0.5	0.4	0	37.8	45.6	0	116	134	0	28	28
2025	11	3	16	40	0	24.7	-1.8	0.945	0.5	0.4	0	38.3	46.4	0	117	136	0	28	28
2025	11	3	16	50	0	25.9	-2.1	0.945	0.5	0.4	0	38.7	46.4	0	118	136	0	28	28
2025	11	3	17	0	0	26.1	-2	0.945	0.3	0.2	0	37.8	46	0	116	135	0	28	28
2025	11	3	17	10	0	25.9	-2.6	0.945	0.5	0.5	0	38.3	46	0	116	135	0	27	28
2025	11	3	17	20	0	26.1	-2.3	0.945	0.5	0.4	0	38.7	46	0	117	135	0	27	28
2025	11	3	17	30	0	26.3	-2.3	0.945	0.5	0.4	0	37.8	46	0	116	135	0	28	28
2025	11	3	17	40	0	26.4	-2.6	0.945	0.6	0.5	0	38.7	46	0	117	135	0	27	28
2025	11	3	17	50	0	25.7	-2.2	0.945	0.5	0.4	0	38.3	46.4	0	117	136	0	28	28
2025	11	3	18	0	0	25.5	-1.8	0.945	0.5	0.5	0	38.7	46.9	0	118	137	0	28	28
2025	11	3	18	10	0	26.4	-1.1	0.945	0.4	0.3	0	38.7	46.9	0	118	137	0	28	28
2025	11	3	18	20	0	25.8	-2.1	0.945	0.5	0.5	0	39.1	47.3	0	118	137	0	27	27
2025	11	3	18	30	0	25.7	-2.2	0.945	0.5	0.5	0	39.1	46.9	0	118	137	0	27	28
2025	11	3	18	40	0	25.9	-1.7	0.945	0.4	0.3	0	39.1	47.3	0	119	138	0	28	28
2025	11	3	18	50	0	26.1	-2.9	0.945	0.5	0.4	0	39.6	47.7	0	120	138	0	28	27
2025	11	3	19	0	0	27.5	-3	0.945	0.4	0.3	0	39.6	47.7	0	119	139	0	27	28
2025	11	3	19	10	0	26.4	-2.1	0.945	0.4	0.3	0	40	47.7	0	120	139	0	27	28
2025	11	3	19	20	0	26.5	-2.1	0.945	0.5	0.4	0	40	47.7	0	120	139	0	27	28
2025	11	3	19	30	0	25.8	-2	0.945	0.3	0.2	0	40.4	48.2	0	121	140	0	27	28
2025	11	3	19	40	0	26.4	-1.9	0.945	0.5	0.5	0	40.9	48.6	0	122	141	0	27	28
2025	11	3	19	50	0	25.1	-0.9	0.945	0.5	0.4	0	40.9	49	0	122	141	0	27	27
2025	11	3	20	0	0	26.6	-1.3	0.945	0.5	0.4	0	40.9	48.6	0	122	141	0	27	28
2025	11	3	20	10	0	27.5	-2.7	0.945	0.6	0.5	0	40.4	48.6	0	121	141	0	27	28
2025	11	3	20	20	0	25.9	-1.6	0.945	0.5	0.5	0	40.4	48.6	0	122	141	0	28	28
2025	11	3	20	30	0	26.4	-1.4	0.944	0.5	0.5	0	40.4	49	0	122	141	0	28	27
2025	11	3	20	40	0	27	-1.7	0.945	0.5	0.4	0	40.9	49	0	122	141	0	27	27
2025	11	3	20	50	0	26.5	-2.6	0.945	0.5	0.5	0	40.4	48.6	0	122	142	0	28	29
2025	11	3	21	0	0	26.7	-1.9	0.944	0.5	0.4	0	40.9	49	0	123	142	0	28	28
2025	11	3	21	10	0	26.4	-2.5	0.945	0.4	0.3	0	41.3	49	0	123	142	0	27	28
2025	11	3	21	20	0	26.4	-1.4	0.944	0.5	0.5	0	41.3	49.5	0	124	143	0	28	28
2025	11	3	21	30	0	26.3	-1.5	0.944	0.5	0.4	0	41.7	49.5	0	124	143	0	27	28
2025	11	3	21	40	0	25.1	-2.6	0.944	0.4	0.3	0	41.7	49.5	0	124	143	0	27	28
2025	11	3	21	50	0	26.3	-3	0.944	0.5	0.5	0	40.9	49.9	0	123	143	0	28	27
2025	11	3	22	0	0	26.4	-3	0.944	0.5	0.4	0	41.3	49.5	0	123	143	0	27	28
2025	11	3	22	10	0	25.5	-2.1	0.944	0.4	0.3	0	41.3	49.9	0	124	144	0	28	28
2025	11	3	22	20	0	27	-3	0.944	0.4	0.3	0	41.3	49	0	124	143	0	28	29
2025	11	3	22	30	0	27.1	-1.7	0.944	0.5	0.4	0	41.3	49.5	0	124	143	0	28	28
2025	11	3	22	40	0	25.4	-2	0.944	0.5	0.4	0	42.1	49.9	0	125	144	0	27	28
2025	11	3	22	50	0	26.3	-1	0.944	0.5	0.4	0	41.3	49.5	0	124	144	0	28	29
2025	11	3	23	0	0	25.6	-1.3	0.944	0.4	0.3	0	40.9	49.9	0	123	144	0	28	28
2025	11	3	23	10	0	26.8	-1.6	0.944	0.5	0.4	0	41.3	49.5	0	123	143	0	27	28
2025	11	3	23	20	0	26.2	-1.6	0.944	0.4	0.3	0	41.7	49.9	0	124	144	0	27	28
2025	11	3	23	30	0	25.8	-1.3	0.945	0.5	0.4	0	41.3	49.5	0	124	143	0	28	28
2025	11	3	23	40	0	26.8	-2.1	0.945	0.5	0.4	0	41.7	49.9	0	124	144	0	27	28
2025	11	3	23	50	0	27.7	-2.3	0.945	0.5	0.4	0	41.3	49	0	123	143	0	27	29

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	4	0	0	0	26.4	-1.5	0.945	0.5	0.4	0	41.3	49.9	0	124	144	0	28	28
2025	11	4	0	10	0	26.5	-2.2	0.945	0.4	0.3	0	40.9	49.9	0	123	144	0	28	28
2025	11	4	0	20	0	26.1	-1.8	0.946	0.5	0.4	0	41.3	49.5	0	123	143	0	27	28
2025	11	4	0	30	0	27.1	-1.7	0.946	0.3	0.2	0	41.7	49.9	0	124	143	0	27	27
2025	11	4	0	40	0	27.9	-2.4	0.946	0.5	0.5	0	41.3	49.5	0	123	143	0	27	28
2025	11	4	0	50	0	27	-1.7	0.946	0.4	0.3	0	40.9	49.5	0	123	143	0	28	28
2025	11	4	1	0	0	26.8	-1.7	0.946	0.5	0.4	0	41.3	49.9	0	123	144	0	27	28
2025	11	4	1	10	0	27	-2.1	0.946	0.5	0.4	0	41.3	49.5	0	123	143	0	27	28
2025	11	4	1	20	0	26	-2.5	0.946	0.4	0.3	0	41.3	49.5	0	123	143	0	27	28
2025	11	4	1	30	0	26.1	-2.2	0.946	0.5	0.4	0	41.3	49.5	0	123	143	0	27	28
2025	11	4	1	40	0	26.5	-2.9	0.946	0.5	0.4	0	40.9	49.5	0	123	143	0	28	28
2025	11	4	1	50	0	27.4	-1.7	0.946	0.5	0.4	0	40.9	49.5	0	122	143	0	27	28
2025	11	4	2	0	0	26.4	-1.5	0.946	0.5	0.5	0	40.4	49.5	0	122	143	0	28	28
2025	11	4	2	10	0	26.7	-1.3	0.946	0.5	0.4	0	40.9	49.9	0	123	143	0	28	27
2025	11	4	2	20	0	27.2	-3.1	0.946	0.6	0.5	0	40.4	49.5	0	122	143	0	28	28
2025	11	4	2	30	0	26.1	-2.1	0.946	0.4	0.3	0	40.4	49.5	0	122	143	0	28	28
2025	11	4	2	40	0	26.8	-1.5	0.946	0.4	0.3	0	40.4	49	0	122	143	0	28	29
2025	11	4	2	50	0	27.2	-2.8	0.946	0.5	0.4	0	40.4	48.6	0	122	142	0	28	29
2025	11	4	3	0	0	27.6	-2.1	0.946	0.5	0.4	0	40.9	49	0	122	143	0	27	29
2025	11	4	3	10	0	27	-1.5	0.946	0.5	0.4	0	40.4	49	0	122	142	0	28	28
2025	11	4	3	20	0	26.8	-1.3	0.946	0.4	0.3	0	40	49.5	0	122	143	0	29	28
2025	11	4	3	30	0	25.9	-1.3	0.946	0.5	0.4	0	40.4	49	0	122	142	0	28	28
2025	11	4	3	40	0	27.4	-2.5	0.946	0.4	0.3	0	40	49	0	121	142	0	28	28
2025	11	4	3	50	0	27.1	-1.4	0.946	0.5	0.4	0	40	48.6	0	121	142	0	28	29
2025	11	4	4	0	0	26	-2.3	0.946	0.5	0.4	0	40.9	49	0	122	142	0	27	28
2025	11	4	4	10	0	26.3	-2	0.946	0.5	0.4	0	40.4	49	0	122	142	0	28	28
2025	11	4	4	20	0	27.1	-2.2	0.945	0.5	0.4	0	40	49	0	121	142	0	28	28
2025	11	4	4	30	0	27.2	-1.8	0.946	0.4	0.3	0	40	49	0	121	142	0	28	28
2025	11	4	4	40	0	26.3	-2.4	0.946	0.5	0.5	0	40	49	0	121	142	0	28	28
2025	11	4	4	50	0	26.3	-2.7	0.946	0.4	0.3	0	40	49	0	121	142	0	28	28
2025	11	4	5	0	0	25.6	-1.3	0.946	0.5	0.4	0	40.4	48.6	0	122	142	0	28	29
2025	11	4	5	10	0	27.6	-1.3	0.946	0.5	0.5	0	40	49	0	121	142	0	28	28
2025	11	4	5	20	0	27.1	-2.9	0.946	0.3	0.2	0	40.4	49	0	121	142	0	27	28
2025	11	4	5	30	0	26.5	-2	0.946	0.4	0.3	0	40	49	0	121	142	0	28	28
2025	11	4	5	40	0	26.6	-1.9	0.946	0.5	0.4	0	40.4	49	0	122	142	0	28	28
2025	11	4	5	50	0	27.1	-2.1	0.945	0.4	0.3	0	40	49.5	0	121	143	0	28	28
2025	11	4	6	0	0	26.7	-1.5	0.945	0.3	0.2	0	40.9	49.5	0	122	143	0	27	28
2025	11	4	6	10	0	26.3	-1.7	0.946	0.4	0.3	0	40	49	0	121	142	0	28	28
2025	11	4	6	20	0	26.3	-2.9	0.946	0.5	0.5	0	40.9	48.6	0	122	142	0	27	29
2025	11	4	6	30	0	26.3	-2.1	0.945	0.4	0.3	0	40.4	49.5	0	122	143	0	28	28
2025	11	4	6	40	0	27.1	-2.5	0.945	0.4	0.3	0	40.4	49	0	122	142	0	28	28
2025	11	4	6	50	0	26.9	-1.6	0.945	0.5	0.4	0	40	48.6	0	121	142	0	28	29
2025	11	4	7	0	0	26.8	-2.1	0.945	0.4	0.3	0	40	49	0	121	142	0	28	28
2025	11	4	7	10	0	26.8	-1.8	0.945	0.4	0.3	0	40	49	0	121	142	0	28	28
2025	11	4	7	20	0	26.6	-1.8	0.945	0.4	0.3	0	40	49	0	121	142	0	28	28
2025	11	4	7	30	0	26.9	-1.7	0.946	0.5	0.5	0	39.6	49	0	121	142	0	29	28
2025	11	4	7	40	0	26.6	-1.5	0.946	0.5	0.4	0	39.6	48.6	0	120	141	0	28	28
2025	11	4	7	50	0	27.5	-1.9	0.946	0.4	0.3	0	40	48.2	0	120	140	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	4	8	0	0	26.5	-2	0.946	0.4	0.3	0	39.1	48.2	0	119	140	0	28	28
2025	11	4	8	10	0	26.1	-3	0.946	0.6	0.5	0	39.1	47.7	0	119	139	0	28	28
2025	11	4	8	20	0	26.8	-1.3	0.946	0.5	0.5	0	39.1	48.2	0	119	140	0	28	28
2025	11	4	8	30	0	25.9	-2.5	0.946	0.4	0.3	0	39.1	47.3	0	119	139	0	28	29
2025	11	4	8	40	0	26.2	-1.3	0.946	0.5	0.4	0	39.1	47.3	0	119	139	0	28	29
2025	11	4	8	50	0	27.1	-1.5	0.946	0.5	0.4	0	37.8	46.4	0	116	137	0	28	29
2025	11	4	9	0	0	26.1	-1.7	0.946	0.4	0.3	0	37.8	46.4	0	116	137	0	28	29
2025	11	4	9	10	0	25.8	-2	0.946	0.4	0.3	0	39.1	48.2	0	119	140	0	28	28
2025	11	4	9	20	0	27	-2.5	0.946	0.5	0.4	0	39.1	47.7	0	119	140	0	28	29
2025	11	4	9	30	0	24.9	-0.9	0.946	0.5	0.5	0	38.7	47.3	0	118	139	0	28	29
2025	11	4	9	40	0	26.9	-2.2	0.946	0.5	0.5	0	39.6	47.7	0	119	140	0	27	29
2025	11	4	9	50	0	26.2	-3	0.946	0.5	0.4	0	41.3	49.9	0	124	145	0	28	29
2025	11	4	10	0	0	27.2	-1.3	0.946	0.5	0.4	0	40.9	49.5	0	123	143	0	28	28
2025	11	4	10	10	0	26.2	-1.7	0.946	0.5	0.4	0	40.4	48.6	0	122	142	0	28	29
2025	11	4	10	20	0	26.1	-0.8	0.946	0.5	0.4	0	38.7	46.9	0	117	137	0	27	28
2025	11	4	10	30	0	26.6	-2.1	0.946	0.5	0.4	0	38.7	47.7	0	118	139	0	28	28
2025	11	4	10	40	0	26.9	-2.2	0.947	0.4	0.3	0	37.4	45.6	0	115	135	0	28	29
2025	11	4	10	50	0	25.8	-2.1	0.947	0.5	0.5	0	37	46	0	114	135	0	28	28
2025	11	4	11	0	0	27.2	-2.2	0.947	0.5	0.4	0	36.5	45.2	0	113	133	0	28	28
2025	11	4	11	10	0	26.3	-2.4	0.947	0.5	0.5	0	36.5	45.2	0	113	133	0	28	28
2025	11	4	11	20	0	26.4	-2.7	0.947	0.5	0.4	0	36.1	44.7	0	112	132	0	28	28
2025	11	4	11	30	0	26.4	-2.6	0.947	0.5	0.4	0	36.1	45.2	0	112	133	0	28	28
2025	11	4	11	40	0	26.8	-1.5	0.947	0.4	0.3	0	36.1	44.7	0	112	132	0	28	28
2025	11	4	11	50	0	25.9	-2.2	0.947	0.5	0.5	0	35.7	44.3	0	111	132	0	28	29
2025	11	4	12	0	0	25.5	-3.9	0.947	0.5	0.4	0	36.1	44.7	0	112	132	0	28	28
2025	11	4	12	10	0	26	-2.6	0.947	0.5	0.4	0	36.1	44.7	0	112	132	0	28	28
2025	11	4	12	20	0	26.8	-3.5	0.947	0.5	0.5	0	35.7	44.3	0	110	131	0	27	28
2025	11	4	12	30	0	26.6	-3.5	0.947	0.4	0.3	0	35.7	44.7	0	111	132	0	28	28
2025	11	4	12	40	0	26.5	-3	0.947	0.4	0.3	0	36.1	44.7	0	111	132	0	27	28
2025	11	4	12	50	0	27	-2	0.947	0.4	0.3	0	35.3	44.3	0	110	131	0	28	28
2025	11	4	13	0	0	27.2	-3.1	0.947	0.4	0.3	0	36.1	44.7	0	111	132	0	27	28
2025	11	4	13	10	0	27	-2.9	0.947	0.5	0.4	0	35.3	44.3	0	110	131	0	28	28
2025	11	4	13	20	0	26.6	-2.3	0.947	0.5	0.4	0	36.1	44.7	0	111	132	0	27	28
2025	11	4	13	30	0	26.7	-2.8	0.948	0.5	0.4	0	35.3	43.9	0	110	131	0	28	29
2025	11	4	13	40	0	27.4	-3.1	0.947	0.5	0.4	0	35.7	44.3	0	111	131	0	28	28
2025	11	4	13	50	0	25.6	-3	0.947	0.5	0.5	0	35.7	43.9	0	110	131	0	27	29
2025	11	4	14	0	0	25.9	-3.4	0.947	0.4	0.3	0	35.3	44.3	0	110	131	0	28	28
2025	11	4	14	10	0	26.8	-3	0.947	0.4	0.3	0	35.3	44.7	0	111	132	0	29	28
2025	11	4	14	20	0	26	-2.4	0.948	0.4	0.3	0	35.7	44.3	0	111	132	0	28	29
2025	11	4	14	30	0	26.6	-3	0.948	0.5	0.4	0	36.5	44.7	0	112	132	0	27	28
2025	11	4	14	40	0	26.3	-1.7	0.947	0.5	0.5	0	35.7	44.7	0	111	132	0	28	28
2025	11	4	14	50	0	26.3	-3.7	0.948	0.4	0.3	0	35.3	43.9	0	110	131	0	28	29
2025	11	4	15	0	0	27	-2.5	0.948	0.5	0.4	0	36.5	45.2	0	112	133	0	27	28
2025	11	4	15	10	0	26.7	-3.2	0.949	0.4	0.3	0	36.1	44.7	0	111	132	0	27	28
2025	11	4	15	20	0	24.8	-2.6	0.949	0.5	0.4	0	37	45.2	0	113	133	0	27	28
2025	11	4	15	30	0	26.4	-3.1	0.949	0.5	0.4	0	36.5	45.2	0	112	133	0	27	28
2025	11	4	15	40	0	27	-1.6	0.949	0.4	0.3	0	37	46.4	0	114	136	0	28	28
2025	11	4	15	50	0	26.3	-2.8	0.949	0.3	0.2	0	37	46	0	113	135	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	4	16	0	0	26.6	-3.3	0.95	0.5	0.4	0	36.5	45.6	0	113	134	0	28	28
2025	11	4	16	10	0	27.1	-2	0.949	0.5	0.4	0	37	46.4	0	114	135	0	28	27
2025	11	4	16	20	0	25.9	-2.7	0.95	0.5	0.4	0	37	46	0	114	135	0	28	28
2025	11	4	16	30	0	26	-3.2	0.95	0.4	0.3	0	37.4	46.4	0	115	136	0	28	28
2025	11	4	16	40	0	26	-3.7	0.95	0.5	0.4	0	37.4	46.4	0	115	136	0	28	28
2025	11	4	16	50	0	26.9	-3.4	0.95	0.5	0.5	0	37	46.4	0	114	136	0	28	28
2025	11	4	17	0	0	25.6	-1.6	0.95	0.5	0.4	0	37.8	46.9	0	116	137	0	28	28
2025	11	4	17	10	0	27.4	-3.1	0.95	0.4	0.3	0	37.4	46	0	114	135	0	27	28
2025	11	4	17	20	0	27.1	-2.1	0.951	0.5	0.4	0	36.5	46	0	113	135	0	28	28
2025	11	4	17	30	0	26.7	-2.1	0.951	0.5	0.4	0	36.5	46.4	0	113	135	0	28	27
2025	11	4	17	40	0	27.1	-2.1	0.952	0.4	0.3	0	36.5	46	0	113	135	0	28	28
2025	11	4	17	50	0	27.3	-1.4	0.952	0.5	0.5	0	37	46.4	0	114	136	0	28	28
2025	11	4	18	0	0	26.6	-1.2	0.952	0.4	0.3	0	37.4	46.4	0	114	136	0	27	28
2025	11	4	18	10	0	28.6	-1.7	0.952	0.5	0.5	0	37	46.4	0	114	136	0	28	28
2025	11	4	18	20	0	27.2	-1.9	0.952	0.4	0.3	0	37	46.4	0	114	136	0	28	28
2025	11	4	18	30	0	27.4	-2.1	0.952	0.4	0.3	0	37.8	46.4	0	115	137	0	27	29
2025	11	4	18	40	0	26.5	-1.7	0.952	0.4	0.3	0	37.8	47.3	0	116	138	0	28	28
2025	11	4	18	50	0	26.9	-2	0.953	0.5	0.4	0	37.8	47.3	0	116	138	0	28	28
2025	11	4	19	0	0	27.7	-1.9	0.953	0.5	0.4	0	38.3	47.7	0	117	139	0	28	28
2025	11	4	19	10	0	26.6	-1.5	0.953	0.5	0.4	0	38.3	47.7	0	117	139	0	28	28
2025	11	4	19	20	0	27	-2.6	0.953	0.5	0.5	0	38.7	47.7	0	117	139	0	27	28
2025	11	4	19	30	0	26.7	-1.1	0.953	0.5	0.4	0	38.3	48.6	0	117	140	0	28	27
2025	11	4	19	40	0	26.7	-1.7	0.953	0.5	0.5	0	38.7	48.2	0	118	140	0	28	28
2025	11	4	19	50	0	27	-1.6	0.953	0.5	0.4	0	38.7	48.2	0	118	140	0	28	28
2025	11	4	20	0	0	28	-1.7	0.953	0.4	0.3	0	38.7	48.2	0	118	140	0	28	28
2025	11	4	20	10	0	26.8	-1.7	0.953	0.4	0.3	0	38.7	48.2	0	118	140	0	28	28
2025	11	4	20	20	0	27.6	-2.5	0.953	0.3	0.2	0	39.1	48.2	0	118	140	0	27	28
2025	11	4	20	30	0	27.6	-2.4	0.953	0.4	0.3	0	39.1	47.7	0	118	140	0	27	29
2025	11	4	20	40	0	26.8	-1.4	0.953	0.5	0.5	0	39.1	48.2	0	119	141	0	28	29
2025	11	4	20	50	0	26.8	-1	0.953	0.5	0.4	0	39.6	48.6	0	119	141	0	27	28
2025	11	4	21	0	0	27.2	-1	0.953	0.5	0.4	0	39.1	49	0	119	141	0	28	27
2025	11	4	21	10	0	27.6	-3	0.953	0.5	0.4	0	39.1	48.6	0	119	141	0	28	28
2025	11	4	21	20	0	27.6	-2.2	0.953	0.5	0.5	0	39.1	48.6	0	119	141	0	28	28
2025	11	4	21	30	0	27.4	-1.7	0.953	0.5	0.4	0	39.6	49	0	120	142	0	28	28
2025	11	4	21	40	0	26.6	-1.2	0.953	0.5	0.4	0	39.6	49	0	120	142	0	28	28
2025	11	4	21	50	0	27.5	-2.1	0.953	0.5	0.4	0	40	49	0	120	142	0	27	28
2025	11	4	22	0	0	26.7	-1.5	0.954	0.4	0.3	0	39.6	49	0	120	142	0	28	28
2025	11	4	22	10	0	25.8	-1.9	0.954	0.5	0.4	0	39.6	49	0	120	142	0	28	28
2025	11	4	22	20	0	27.1	-0.9	0.954	0.5	0.4	0	39.1	49	0	119	142	0	28	28
2025	11	4	22	30	0	27.4	-2.1	0.954	0.4	0.3	0	40	49	0	120	142	0	27	28
2025	11	4	22	40	0	27.5	-1.1	0.954	0.5	0.4	0	40	49.5	0	120	143	0	27	28
2025	11	4	22	50	0	27.1	-1.9	0.954	0.6	0.5	0	39.1	49	0	119	142	0	28	28
2025	11	4	23	0	0	26.5	-2.5	0.954	0.5	0.5	0	39.1	49	0	119	142	0	28	28
2025	11	4	23	10	0	26.9	-2	0.954	0.4	0.3	0	40	49.5	0	120	143	0	27	28
2025	11	4	23	20	0	27.8	-2	0.954	0.5	0.5	0	39.6	49	0	119	142	0	27	28
2025	11	4	23	30	0	27.9	-2.1	0.954	0.5	0.4	0	39.6	49.5	0	120	142	0	28	27
2025	11	4	23	40	0	26.2	-1	0.954	0.5	0.4	0	40	49	0	120	142	0	27	28
2025	11	4	23	50	0	27.1	-2.1	0.954	0.5	0.4	0	39.6	49.5	0	120	143	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	5	0	0	0	28.5	-2.6	0.954	0.5	0.4	0	39.6	48.6	0	120	142	0	28	29
2025	11	5	0	10	0	26.7	-2.1	0.955	0.4	0.3	0	39.1	49.5	0	119	142	0	28	27
2025	11	5	0	20	0	27.7	-1.7	0.956	0.5	0.4	0	39.1	48.2	0	119	141	0	28	29
2025	11	5	0	30	0	27.8	-1.8	0.956	0.5	0.5	0	39.6	48.2	0	119	141	0	27	29
2025	11	5	0	40	0	27.4	-1.7	0.957	0.3	0.2	0	39.1	48.6	0	119	141	0	28	28
2025	11	5	0	50	0	27.4	-2.2	0.957	0.5	0.5	0	39.6	49	0	119	142	0	27	28
2025	11	5	1	0	0	27.1	-1.4	0.957	0.3	0.2	0	39.6	49	0	119	142	0	27	28
2025	11	5	1	10	0	26.4	-2.3	0.958	0.5	0.4	0	38.7	49	0	118	142	0	28	28
2025	11	5	1	20	0	25.9	-1.2	0.958	0.4	0.3	0	39.1	49	0	119	142	0	28	28
2025	11	5	1	30	0	27.3	-2.3	0.958	0.4	0.3	0	38.7	48.6	0	118	141	0	28	28
2025	11	5	1	40	0	26.4	-1.5	0.958	0.4	0.3	0	39.1	48.2	0	119	141	0	28	29
2025	11	5	1	50	0	26.4	-1.2	0.958	0.4	0.3	0	38.3	48.6	0	117	141	0	28	28
2025	11	5	2	0	0	27.8	-1.8	0.958	0.3	0.2	0	38.3	48.6	0	117	141	0	28	28
2025	11	5	2	10	0	26.4	-0.9	0.959	0.4	0.3	0	38.3	48.2	0	117	141	0	28	29
2025	11	5	2	20	0	27.7	-1.4	0.959	0.5	0.4	0	38.3	48.6	0	117	141	0	28	28
2025	11	5	2	30	0	26.9	-2.9	0.958	0.4	0.3	0	37.8	48.2	0	116	141	0	28	29
2025	11	5	2	40	0	26.4	-1.6	0.959	0.4	0.3	0	38.3	48.6	0	117	141	0	28	28
2025	11	5	2	50	0	26.8	-1.3	0.959	0.7	0.6	0	37.8	48.6	0	116	141	0	28	28
2025	11	5	3	0	0	27.2	-1.1	0.959	0.5	0.4	0	38.3	48.2	0	116	140	0	27	28
2025	11	5	3	10	0	27.8	-2	0.959	0.4	0.3	0	37.8	48.6	0	116	141	0	28	28
2025	11	5	3	20	0	27.2	-2.2	0.959	0.4	0.3	0	38.3	48.2	0	116	141	0	27	29
2025	11	5	3	30	0	27.8	-1.2	0.959	0.4	0.3	0	37.4	48.2	0	115	140	0	28	28
2025	11	5	3	40	0	26.3	-2.4	0.959	0.5	0.4	0	38.3	48.2	0	116	139	0	27	27
2025	11	5	3	50	0	26.9	-1.7	0.959	0.5	0.5	0	37.4	48.6	0	116	141	0	29	28
2025	11	5	4	0	0	27.6	-2.3	0.959	0.4	0.3	0	37.8	48.2	0	116	140	0	28	28
2025	11	5	4	10	0	27.2	-1.4	0.959	0.5	0.4	0	37.4	48.2	0	115	140	0	28	28
2025	11	5	4	20	0	27.1	-1.5	0.959	0.5	0.5	0	37.8	48.2	0	116	140	0	28	28
2025	11	5	4	30	0	27.7	-3	0.959	0.4	0.3	0	37.4	48.6	0	115	141	0	28	28
2025	11	5	4	40	0	26.5	-2.6	0.959	0.5	0.4	0	37.8	48.2	0	116	140	0	28	28
2025	11	5	4	50	0	27.5	-2.9	0.959	0.4	0.3	0	37.8	48.6	0	116	141	0	28	28
2025	11	5	5	0	0	26.7	-1.7	0.959	0.5	0.4	0	37.8	48.6	0	116	141	0	28	28
2025	11	5	5	10	0	27.9	-2.3	0.959	0.5	0.5	0	37.4	47.7	0	115	140	0	28	29
2025	11	5	5	20	0	27.5	-2.4	0.959	0.5	0.4	0	38.3	48.2	0	116	140	0	27	28
2025	11	5	5	30	0	27.4	-0.6	0.959	0.4	0.3	0	37.8	48.6	0	116	141	0	28	28
2025	11	5	5	40	0	27.8	-1.8	0.959	0.5	0.4	0	37.8	48.6	0	116	141	0	28	28
2025	11	5	5	50	0	27.5	-1	0.959	0.4	0.3	0	38.3	48.6	0	116	141	0	27	28
2025	11	5	6	0	0	27.4	-2	0.959	0.4	0.3	0	38.3	48.6	0	116	141	0	27	28
2025	11	5	6	10	0	26.6	-1.2	0.959	0.4	0.3	0	37.8	48.2	0	116	141	0	28	29
2025	11	5	6	20	0	27.4	-1.3	0.96	0.5	0.4	0	37.8	48.2	0	116	141	0	28	29
2025	11	5	6	30	0	27.8	-2	0.959	0.4	0.3	0	37.8	48.6	0	116	141	0	28	28
2025	11	5	6	40	0	27.2	-0.8	0.96	0.5	0.5	0	37.8	48.6	0	116	141	0	28	28
2025	11	5	6	50	0	27.8	-2.2	0.959	0.5	0.4	0	37.8	48.2	0	116	140	0	28	28
2025	11	5	7	0	0	27.1	-2.1	0.959	0.4	0.3	0	37.8	48.6	0	116	141	0	28	28
2025	11	5	7	10	0	27.5	-2.2	0.96	0.5	0.4	0	37.4	48.2	0	115	140	0	28	28
2025	11	5	7	20	0	27.5	-1.2	0.96	0.4	0.3	0	37.8	47.7	0	115	140	0	27	29
2025	11	5	7	30	0	27.5	-2.4	0.96	0.5	0.5	0	37.4	48.2	0	115	140	0	28	28
2025	11	5	7	40	0	27.1	-2.3	0.96	0.4	0.3	0	37.4	48.2	0	115	140	0	28	28
2025	11	5	7	50	0	28.2	-2	0.96	0.5	0.5	0	37	47.3	0	114	139	0	28	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	5	8	0	0	26.8	-1.7	0.96	0.3	0.2	0	37	47.7	0	114	139	0	28	28
2025	11	5	8	10	0	27.7	-2.7	0.96	0.5	0.4	0	37	46.9	0	113	138	0	27	29
2025	11	5	8	20	0	27.5	-2.5	0.96	0.5	0.4	0	37	47.3	0	114	138	0	28	28
2025	11	5	8	30	0	27.1	-2	0.96	0.5	0.4	0	36.5	47.3	0	113	138	0	28	28
2025	11	5	8	40	0	26.9	-1.2	0.96	0.5	0.5	0	36.5	47.3	0	113	138	0	28	28
2025	11	5	8	50	0	27.4	-1.7	0.96	0.3	0.2	0	36.1	46.9	0	112	137	0	28	28
2025	11	5	9	0	0	27	-0.8	0.96	0.5	0.4	0	36.1	46	0	112	136	0	28	29
2025	11	5	9	10	0	27.4	-3	0.96	0.4	0.3	0	36.1	46.4	0	111	136	0	27	28
2025	11	5	9	20	0	27	-1.7	0.96	0.3	0.2	0	35.7	46	0	111	135	0	28	28
2025	11	5	9	30	0	27.5	-2.9	0.96	0.5	0.4	0	35.7	46	0	111	135	0	28	28
2025	11	5	9	40	0	27.9	-2.8	0.96	0.3	0.2	0	35.3	45.6	0	110	134	0	28	28
2025	11	5	9	50	0	26.9	-2.4	0.96	0.4	0.3	0	36.1	46.9	0	112	137	0	28	28
2025	11	5	10	0	0	26.2	-1.3	0.96	0.6	0.5	0	35.7	46	0	111	135	0	28	28
2025	11	5	10	10	0	27.4	-2.5	0.96	0.4	0.3	0	34.8	45.2	0	109	134	0	28	29
2025	11	5	10	20	0	26	-1.5	0.961	0.3	0.2	0	35.7	45.2	0	110	133	0	27	28
2025	11	5	10	30	0	28.1	-3.6	0.961	0.4	0.3	0	35.3	45.2	0	110	133	0	28	28
2025	11	5	10	40	0	27.1	-2.6	0.961	0.4	0.3	0	34.4	44.7	0	109	133	0	29	29
2025	11	5	10	50	0	27	-1.7	0.961	0.5	0.5	0	34.8	44.7	0	108	132	0	27	28
2025	11	5	11	0	0	26.3	-2.3	0.961	0.4	0.3	0	34.4	44.3	0	108	131	0	28	28
2025	11	5	11	10	0	26.3	-2.3	0.961	0.5	0.4	0	34	43.9	0	107	131	0	28	29
2025	11	5	11	20	0	26.8	-3.4	0.961	0.5	0.4	0	34	44.3	0	107	131	0	28	28
2025	11	5	11	30	0	27.7	-2.2	0.961	0.5	0.4	0	34.4	44.3	0	108	132	0	28	29
2025	11	5	11	40	0	28.2	-2.7	0.962	0.5	0.4	0	35.3	45.2	0	109	133	0	27	28
2025	11	5	11	50	0	26.7	-2.5	0.962	0.5	0.4	0	35.3	45.2	0	110	133	0	28	28
2025	11	5	12	0	0	26.4	-2.4	0.962	0.5	0.4	0	34.8	44.7	0	109	132	0	28	28
2025	11	5	12	10	0	27	-3.4	0.962	0.5	0.4	0	34.4	44.3	0	108	131	0	28	28
2025	11	5	12	20	0	27.6	-1.4	0.962	0.4	0.3	0	34.8	44.3	0	108	131	0	27	28
2025	11	5	12	30	0	27.7	-3	0.962	0.5	0.5	0	34.4	44.3	0	108	131	0	28	28
2025	11	5	12	40	0	27	-2.3	0.962	0.5	0.4	0	34.8	44.3	0	108	131	0	27	28
2025	11	5	12	50	0	27.5	-2.6	0.963	0.5	0.4	0	34	44.3	0	107	131	0	28	28
2025	11	5	13	0	0	26.9	-4	0.962	0.4	0.3	0	34.4	44.7	0	108	132	0	28	28
2025	11	5	13	10	0	27.3	-3	0.963	0.5	0.4	0	34.8	45.2	0	109	133	0	28	28
2025	11	5	13	20	0	26.9	-2.3	0.963	0.4	0.3	0	35.3	45.6	0	110	134	0	28	28
2025	11	5	13	30	0	26.7	-3.1	0.963	0.4	0.3	0	36.5	46.9	0	113	137	0	28	28
2025	11	5	13	40	0	27.9	-3.6	0.964	0.5	0.4	0	37	46.9	0	113	137	0	27	28
2025	11	5	13	50	0	26.1	-2.8	0.963	0.5	0.4	0	36.5	46.9	0	113	137	0	28	28
2025	11	5	14	0	0	27.1	-2.6	0.964	0.3	0.2	0	37.4	47.3	0	114	138	0	27	28
2025	11	5	14	10	0	28	-1.3	0.964	0.4	0.3	0	37	47.3	0	114	138	0	28	28
2025	11	5	14	20	0	27.6	-2.5	0.963	0.5	0.4	0	36.5	46.9	0	113	137	0	28	28
2025	11	5	14	30	0	28.5	-1.7	0.964	0.4	0.3	0	37	46.9	0	113	137	0	27	28
2025	11	5	14	40	0	26.5	-2.2	0.964	0.4	0.3	0	36.5	47.3	0	113	138	0	28	28
2025	11	5	14	50	0	26.6	-2.5	0.964	0.3	0.2	0	36.5	46.9	0	113	137	0	28	28
2025	11	5	15	0	0	29	-2.9	0.964	0.4	0.3	0	36.5	47.3	0	113	137	0	28	27
2025	11	5	15	10	0	27.4	-2.3	0.964	0.3	0.2	0	37	46.9	0	113	137	0	27	28
2025	11	5	15	20	0	27.3	-2.1	0.964	0.4	0.3	0	37	46.9	0	113	137	0	27	28
2025	11	5	15	30	0	27.5	-2.4	0.965	0.5	0.5	0	37	46.9	0	113	136	0	27	27
2025	11	5	15	40	0	27.2	-1.1	0.965	0.5	0.5	0	37	46.4	0	113	136	0	27	28
2025	11	5	15	50	0	27.7	-2.7	0.965	0.4	0.3	0	36.5	46.9	0	113	137	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	5	16	0	0	28.4	-2.8	0.965	0.3	0.2	0	37	46.9	0	113	137	0	27	28
2025	11	5	16	10	0	26.5	-2.6	0.965	0.5	0.4	0	37	46.9	0	113	137	0	27	28
2025	11	5	16	20	0	27.6	-2.5	0.965	0.4	0.3	0	36.5	46.9	0	113	137	0	28	28
2025	11	5	16	30	0	27.9	-2.5	0.965	0.5	0.5	0	36.5	46.9	0	113	137	0	28	28
2025	11	5	16	40	0	28.1	-2.1	0.965	0.4	0.3	0	37	47.7	0	114	138	0	28	27
2025	11	5	16	50	0	27.2	-1.4	0.965	0.5	0.4	0	37.4	47.3	0	114	138	0	27	28
2025	11	5	17	0	0	27.6	-1.5	0.965	0.3	0.2	0	36.5	47.3	0	113	138	0	28	28
2025	11	5	17	10	0	28.4	-1.3	0.965	0.4	0.3	0	37	47.3	0	113	137	0	27	27
2025	11	5	17	20	0	27.5	-1.1	0.965	0.5	0.4	0	37.4	47.7	0	114	139	0	27	28
2025	11	5	17	30	0	27.8	-2	0.966	0.4	0.3	0	36.5	47.3	0	113	138	0	28	28
2025	11	5	17	40	0	27	-2.4	0.966	0.5	0.4	0	37.4	48.2	0	115	140	0	28	28
2025	11	5	17	50	0	28.1	-2	0.966	0.5	0.4	0	38.7	48.6	0	117	141	0	27	28
2025	11	5	18	0	0	27.7	-2.2	0.966	0.5	0.5	0	39.6	49.5	0	119	143	0	27	28
2025	11	5	18	10	0	27.7	-2.4	0.966	0.5	0.4	0	40.9	51.6	0	122	147	0	27	27
2025	11	5	18	20	0	27.1	-2	0.966	0.4	0.3	0	41.3	52.5	0	124	149	0	28	27
2025	11	5	18	30	0	28.2	-1.4	0.966	0.5	0.4	0	41.3	52.5	0	124	149	0	28	27
2025	11	5	18	40	0	26.7	-2.2	0.966	0.5	0.5	0	40.9	51.6	0	123	148	0	28	28
2025	11	5	18	50	0	27.4	-2.1	0.967	0.5	0.4	0	41.3	52.5	0	124	150	0	28	28
2025	11	5	19	0	0	28.2	-1.1	0.967	0.5	0.5	0	42.1	52.5	0	125	150	0	27	28
2025	11	5	19	10	0	26.9	-1.3	0.966	0.5	0.4	0	42.1	52.9	0	126	151	0	28	28
2025	11	5	19	20	0	27.8	-2	0.967	0.5	0.4	0	42.6	53.3	0	126	152	0	27	28
2025	11	5	19	30	0	28.8	-2.1	0.967	0.5	0.5	0	42.1	52.9	0	126	151	0	28	28
2025	11	5	19	40	0	27.4	-2.1	0.967	0.5	0.4	0	42.6	52.9	0	126	151	0	27	28
2025	11	5	19	50	0	27.4	-2.3	0.967	0.4	0.3	0	42.6	54.2	0	127	153	0	28	27
2025	11	5	20	0	0	28.3	-1.9	0.967	0.4	0.3	0	42.6	53.8	0	127	153	0	28	28
2025	11	5	20	10	0	27.6	-2.8	0.967	0.4	0.3	0	43	53.8	0	127	153	0	27	28
2025	11	5	20	20	0	28	-1.1	0.967	0.5	0.4	0	42.1	52.9	0	126	151	0	28	28
2025	11	5	20	30	0	26.5	-1.1	0.967	0.5	0.4	0	42.1	52.9	0	126	151	0	28	28
2025	11	5	20	40	0	28.6	-1.9	0.967	0.5	0.5	0	41.7	52.9	0	125	151	0	28	28
2025	11	5	20	50	0	28	-0.1	0.967	0.5	0.5	0	42.6	53.3	0	126	152	0	27	28
2025	11	5	21	0	0	27.4	-1.3	0.967	0.5	0.4	0	42.1	53.3	0	126	152	0	28	28
2025	11	5	21	10	0	27.8	-1.7	0.967	0.5	0.4	0	41.7	53.3	0	125	152	0	28	28
2025	11	5	21	20	0	28.2	-1.3	0.967	0.5	0.4	0	41.7	52.9	0	125	151	0	28	28
2025	11	5	21	30	0	28.2	-2.2	0.967	0.6	0.5	0	41.7	52.9	0	125	151	0	28	28
2025	11	5	21	40	0	28.1	-1.7	0.966	0.4	0.3	0	41.7	52.9	0	125	151	0	28	28
2025	11	5	21	50	0	27.8	-2.2	0.966	0.5	0.4	0	41.7	52.9	0	125	151	0	28	28
2025	11	5	22	0	0	27.5	-2.4	0.967	0.5	0.4	0	41.7	53.3	0	125	151	0	28	27
2025	11	5	22	10	0	27.7	-2.4	0.966	0.4	0.3	0	41.7	52.5	0	124	150	0	27	28
2025	11	5	22	20	0	28.3	-1.6	0.966	0.5	0.4	0	41.7	52.5	0	124	150	0	27	28
2025	11	5	22	30	0	28.7	-1.3	0.967	0.5	0.5	0	40.9	52	0	123	149	0	28	28
2025	11	5	22	40	0	27.6	-2.3	0.967	0.5	0.4	0	41.3	52	0	123	149	0	27	28
2025	11	5	22	50	0	27.9	-1.8	0.966	0.4	0.3	0	41.3	51.6	0	123	149	0	27	29
2025	11	5	23	0	0	27.1	-1.7	0.966	0.5	0.4	0	40.9	52	0	123	149	0	28	28
2025	11	5	23	10	0	28.4	-1.7	0.966	0.4	0.3	0	41.3	52	0	123	149	0	27	28
2025	11	5	23	20	0	27.7	-2.5	0.966	0.5	0.4	0	40.4	52	0	122	149	0	28	28
2025	11	5	23	30	0	27.7	-2.1	0.967	0.5	0.5	0	41.3	52	0	123	149	0	27	28
2025	11	5	23	40	0	26.6	-1.8	0.967	0.4	0.3	0	40.9	52	0	123	149	0	28	28
2025	11	5	23	50	0	24	2.3	0.968	0.5	0.4	0	40.4	36.5	0	122	113	0	28	28

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	6	0	0	0	26	-0.9	0.968	0.5	0.4	0	41.3	52	0	124	149	0	28	28
2025	11	6	0	10	0	26.7	-1.9	0.968	0.4	0.3	0	41.3	52	0	123	149	0	27	28
2025	11	6	0	20	0	27.2	-2.9	0.968	0.5	0.4	0	40.9	52	0	123	149	0	28	28
2025	11	6	0	30	0	26.7	-2.9	0.969	0.5	0.4	0	41.3	51.2	0	123	147	0	27	28
2025	11	6	0	40	0	26.3	-1.3	0.97	0.3	0.2	0	40	50.3	0	120	145	0	27	28
2025	11	6	0	50	0	28.6	-2.1	0.97	0.4	0.3	0	40	52	0	120	149	0	27	28
2025	11	6	1	0	0	28	-1.3	0.97	0.4	0.3	0	39.6	52	0	120	149	0	28	28
2025	11	6	1	10	0	26.5	-1.3	0.971	0.4	0.3	0	40	52	0	121	149	0	28	28
2025	11	6	1	20	0	27.8	-2.1	0.971	0.5	0.4	0	40	52	0	120	149	0	27	28
2025	11	6	1	30	0	27.8	-3	0.972	0.4	0.3	0	39.6	52	0	120	149	0	28	28
2025	11	6	1	40	0	27.1	-1.3	0.972	0.4	0.3	0	40	52	0	120	149	0	27	28
2025	11	6	1	50	0	26.7	-2.1	0.972	0.5	0.5	0	40	52.5	0	120	149	0	27	27
2025	11	6	2	0	0	27.6	-1.9	0.972	0.5	0.4	0	39.1	52	0	119	149	0	28	28
2025	11	6	2	10	0	25.8	-2.5	0.972	0.4	0.3	0	39.1	52	0	119	149	0	28	28
2025	11	6	2	20	0	26.3	-2.3	0.972	0.4	0.3	0	39.1	52	0	119	149	0	28	28
2025	11	6	2	30	0	27.4	-2.6	0.973	0.5	0.4	0	39.1	52	0	119	149	0	28	28
2025	11	6	2	40	0	27.3	-2.1	0.973	0.5	0.4	0	39.1	52	0	119	149	0	28	28
2025	11	6	2	50	0	27.3	-2.2	0.973	0.5	0.4	0	39.6	52	0	119	149	0	27	28
2025	11	6	3	0	0	27.3	-2.2	0.973	0.5	0.4	0	39.1	52	0	119	149	0	28	28
2025	11	6	3	10	0	27.6	-2.4	0.973	0.4	0.3	0	39.1	52	0	119	149	0	28	28
2025	11	6	3	20	0	27.5	-1.4	0.973	0.4	0.3	0	39.1	52	0	119	149	0	28	28
2025	11	6	3	30	0	27.7	-2.5	0.973	0.5	0.4	0	39.6	52	0	119	149	0	27	28
2025	11	6	3	40	0	27.9	-1	0.973	0.5	0.4	0	39.1	51.6	0	118	149	0	27	29
2025	11	6	3	50	0	28.5	-1.3	0.974	0.4	0.3	0	39.1	52	0	119	149	0	28	28
2025	11	6	4	0	0	27.7	-2	0.974	0.5	0.4	0	38.7	52	0	118	149	0	28	28
2025	11	6	4	10	0	28	-2.1	0.974	0.5	0.4	0	39.1	51.6	0	118	149	0	27	29
2025	11	6	4	20	0	28	-1.6	0.974	0.5	0.4	0	38.7	52	0	118	149	0	28	28
2025	11	6	4	30	0	27.7	-1.7	0.974	0.4	0.3	0	38.7	52	0	118	149	0	28	28
2025	11	6	4	40	0	27.5	-2.4	0.974	0.5	0.4	0	39.1	52	0	118	149	0	27	28
2025	11	6	4	50	0	28	-2.3	0.974	0.4	0.3	0	39.1	52	0	118	149	0	27	28
2025	11	6	5	0	0	27.6	-2.4	0.974	0.5	0.4	0	39.1	52.5	0	118	150	0	27	28
2025	11	6	5	10	0	27.5	-1.9	0.974	0.5	0.4	0	38.7	52.5	0	118	150	0	28	28
2025	11	6	5	20	0	28.8	-1.9	0.974	0.5	0.4	0	39.6	52	0	120	149	0	28	28
2025	11	6	5	30	0	26.7	-1.1	0.974	0.5	0.4	0	39.6	52.5	0	120	150	0	28	28
2025	11	6	5	40	0	28.2	-2.1	0.975	0.4	0.3	0	39.6	52	0	120	149	0	28	28
2025	11	6	5	50	0	26.9	-0.7	0.975	0.4	0.3	0	39.6	52	0	120	149	0	28	28
2025	11	6	6	0	0	28.5	-1.5	0.975	0.5	0.4	0	40	52	0	120	149	0	27	28
2025	11	6	6	10	0	28.5	-1.5	0.975	0.5	0.4	0	39.6	52.5	0	120	150	0	28	28
2025	11	6	6	20	0	27.9	-2.5	0.975	0.5	0.5	0	39.6	52.5	0	120	150	0	28	28
2025	11	6	6	30	0	28.2	-2	0.975	0.3	0.2	0	39.6	52.5	0	120	150	0	28	28
2025	11	6	6	40	0	27.8	-2.2	0.975	0.4	0.3	0	39.6	52.5	0	120	150	0	28	28
2025	11	6	6	50	0	28	-1.3	0.975	0.5	0.4	0	39.6	52.9	0	120	150	0	28	27
2025	11	6	7	0	0	28.4	-2.2	0.975	0.5	0.4	0	39.6	52.9	0	120	150	0	28	27
2025	11	6	7	10	0	27.2	-1.5	0.975	0.5	0.4	0	40	52.5	0	120	150	0	27	28
2025	11	6	7	20	0	27.8	-2.4	0.975	0.4	0.3	0	40	52.5	0	120	150	0	27	28
2025	11	6	7	30	0	27	-1.7	0.975	0.5	0.4	0	39.6	52.5	0	120	150	0	28	28
2025	11	6	7	40	0	26.7	-0.7	0.975	0.5	0.4	0	39.6	52.5	0	120	150	0	28	28
2025	11	6	7	50	0	28	-1.8	0.975	0.5	0.4	0	39.1	52.5	0	119	150	0	28	28

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	6	8	0	0	28.3	-0.8	0.975	0.5	0.5	0	38.7	52	0	119	149	0	29	28
2025	11	6	8	10	0	28	-1	0.975	0.5	0.4	0	39.6	52	0	119	149	0	27	28
2025	11	6	8	20	0	28.5	-1.5	0.975	0.4	0.3	0	39.1	52	0	119	149	0	28	28
2025	11	6	8	30	0	27.7	-1.8	0.975	0.5	0.5	0	39.6	52	0	119	149	0	27	28
2025	11	6	8	40	0	27.9	-2.1	0.975	0.5	0.5	0	39.1	51.6	0	119	149	0	28	29
2025	11	6	8	50	0	27.4	-2.1	0.975	0.5	0.4	0	38.7	51.6	0	118	148	0	28	28
2025	11	6	9	0	0	27.8	-1.3	0.975	0.4	0.3	0	38.7	51.6	0	118	148	0	28	28
2025	11	6	9	10	0	27.7	-2.1	0.975	0.5	0.4	0	38.7	51.6	0	118	148	0	28	28
2025	11	6	9	20	0	28.2	-1.7	0.976	0.5	0.5	0	38.7	51.2	0	118	147	0	28	28
2025	11	6	9	30	0	28.5	-1.7	0.976	0.4	0.3	0	38.3	51.2	0	117	147	0	28	28
2025	11	6	9	40	0	28.2	-1.4	0.976	0.5	0.4	0	38.3	50.7	0	117	146	0	28	28
2025	11	6	9	50	0	27.5	-2.6	0.976	0.5	0.4	0	38.3	50.7	0	117	146	0	28	28
2025	11	6	10	0	0	27.9	-2.1	0.976	0.4	0.3	0	38.3	50.7	0	117	146	0	28	28
2025	11	6	10	10	0	28.2	-2.6	0.976	0.3	0.2	0	37.8	50.3	0	116	145	0	28	28
2025	11	6	10	20	0	28.1	-0.8	0.976	0.5	0.4	0	37.4	49.9	0	115	144	0	28	28
2025	11	6	10	30	0	28.7	-0.8	0.976	0.3	0.2	0	37	49.9	0	114	144	0	28	28
2025	11	6	10	40	0	27.9	-1.8	0.976	0.4	0.3	0	37	49.9	0	114	144	0	28	28
2025	11	6	10	50	0	28.8	-2	0.976	0.4	0.3	0	36.5	49	0	113	143	0	28	29
2025	11	6	11	0	0	27.9	-2.7	0.976	0.5	0.4	0	37	49	0	113	143	0	27	29
2025	11	6	11	10	0	27.3	-1.4	0.977	0.4	0.3	0	37	49	0	113	142	0	27	28
2025	11	6	11	20	0	28	-2.2	0.977	0.5	0.5	0	36.1	49	0	112	142	0	28	28
2025	11	6	11	30	0	27.5	-1	0.977	0.5	0.5	0	36.1	48.6	0	112	141	0	28	28
2025	11	6	11	40	0	28.8	-2.1	0.977	0.5	0.5	0	36.1	49	0	112	142	0	28	28
2025	11	6	11	50	0	28.4	-2.5	0.977	0.6	0.5	0	36.5	48.6	0	112	141	0	27	28
2025	11	6	12	0	0	28.2	-1.8	0.977	0.4	0.3	0	35.7	48.6	0	111	141	0	28	28
2025	11	6	12	10	0	27.4	-2.1	0.977	0.4	0.3	0	36.1	48.6	0	112	141	0	28	28
2025	11	6	12	20	0	28.7	-1.2	0.977	0.3	0.2	0	35.7	48.2	0	111	141	0	28	29
2025	11	6	12	30	0	28.1	-1.2	0.978	0.3	0.2	0	36.1	48.6	0	112	141	0	28	28
2025	11	6	12	40	0	27.9	-1.3	0.978	0.5	0.4	0	35.7	48.6	0	111	141	0	28	28
2025	11	6	12	50	0	27.9	-2	0.978	0.5	0.4	0	35.7	48.2	0	111	140	0	28	28
2025	11	6	13	0	0	27.8	-1.3	0.978	0.4	0.3	0	35.7	48.2	0	111	140	0	28	28
2025	11	6	13	10	0	27.7	-2.2	0.978	0.5	0.4	0	35.7	48.6	0	111	141	0	28	28
2025	11	6	13	20	0	28.6	-1.7	0.978	0.4	0.3	0	36.1	48.6	0	111	141	0	27	28
2025	11	6	13	30	0	27.9	-1.7	0.978	0.5	0.4	0	36.1	48.6	0	112	141	0	28	28
2025	11	6	13	40	0	29.1	-2	0.978	0.4	0.3	0	36.5	48.6	0	112	141	0	27	28
2025	11	6	13	50	0	27.6	-0.5	0.978	0.4	0.3	0	35.7	48.6	0	111	141	0	28	28
2025	11	6	14	0	0	27.7	-2.6	0.978	0.5	0.4	0	36.1	48.2	0	111	140	0	27	28
2025	11	6	14	10	0	28.3	-2.1	0.979	0.3	0.2	0	36.1	49	0	111	141	0	27	27
2025	11	6	14	20	0	28.1	-2.5	0.979	0.5	0.4	0	36.1	48.2	0	111	140	0	27	28
2025	11	6	14	30	0	27.9	-2.3	0.979	0.5	0.4	0	36.1	48.6	0	111	141	0	27	28
2025	11	6	14	40	0	28	-2.1	0.979	0.5	0.4	0	35.7	48.2	0	111	140	0	28	28
2025	11	6	14	50	0	28.7	-1.7	0.979	0.5	0.5	0	35.7	48.6	0	111	141	0	28	28
2025	11	6	15	0	0	27.7	-1.6	0.979	0.5	0.4	0	35.7	48.6	0	111	141	0	28	28
2025	11	6	15	10	0	27.3	-2	0.979	0.4	0.3	0	36.1	48.6	0	112	141	0	28	28
2025	11	6	15	20	0	29.2	-1.9	0.979	0.3	0.2	0	36.5	48.6	0	112	141	0	27	28
2025	11	6	15	30	0	28	-2.1	0.979	0.4	0.3	0	36.5	49	0	112	141	0	27	27
2025	11	6	15	40	0	29.1	-1.7	0.979	0.5	0.4	0	36.1	49	0	111	141	0	27	27
2025	11	6	15	50	0	27.8	-2.3	0.979	0.4	0.3	0	36.1	49	0	112	142	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	6	16	0	0	29.3	-1.5	0.979	0.5	0.5	0	37	49.5	0	113	142	0	27	27
2025	11	6	16	10	0	29.1	-1.7	0.979	0.4	0.3	0	37	49.5	0	113	143	0	27	28
2025	11	6	16	20	0	28.5	-1.6	0.979	0.4	0.3	0	36.5	49.5	0	113	142	0	28	27
2025	11	6	16	30	0	29	-1.6	0.979	0.5	0.4	0	37	49.5	0	113	143	0	27	28
2025	11	6	16	40	0	29.1	-2.8	0.979	0.4	0.3	0	37	49.5	0	113	143	0	27	28
2025	11	6	16	50	0	29.1	0.2	0.979	0.5	0.5	0	36.1	49.9	0	112	143	0	28	27
2025	11	6	17	0	0	29	-0.8	0.98	0.5	0.4	0	36.1	49.5	0	111	143	0	27	28
2025	11	6	17	10	0	27.4	-1.7	0.98	0.5	0.4	0	35.7	49.5	0	110	143	0	27	28
2025	11	6	17	20	0	29.3	-2.7	0.98	0.5	0.4	0	35.3	49.9	0	110	143	0	28	27
2025	11	6	17	30	0	28.3	-1.7	0.98	0.5	0.4	0	35.3	49.5	0	110	143	0	28	28
2025	11	6	17	40	0	28.7	-2.9	0.98	0.5	0.4	0	36.1	49.5	0	111	143	0	27	28
2025	11	6	17	50	0	28.8	-1.7	0.98	0.5	0.5	0	36.1	49.5	0	111	143	0	27	28
2025	11	6	18	0	0	28	-0.8	0.98	0.5	0.4	0	35.7	49.9	0	111	144	0	28	28
2025	11	6	18	10	0	27.8	-1.2	0.98	0.4	0.3	0	36.1	49.9	0	112	144	0	28	28
2025	11	6	18	20	0	28.3	-1.3	0.98	0.5	0.5	0	36.5	50.3	0	112	144	0	27	27
2025	11	6	18	30	0	28.9	-0.4	0.98	0.4	0.3	0	36.1	50.3	0	112	145	0	28	28
2025	11	6	18	40	0	28.9	-1.9	0.98	0.4	0.3	0	37.4	50.7	0	115	146	0	28	28
2025	11	6	18	50	0	27.5	-1.5	0.98	0.4	0.3	0	38.3	50.7	0	116	146	0	27	28
2025	11	6	19	0	0	28.2	-1.3	0.981	0.5	0.4	0	37.8	50.7	0	116	146	0	28	28
2025	11	6	19	10	0	28.7	-1.4	0.981	0.4	0.3	0	38.3	51.6	0	116	147	0	27	27
2025	11	6	19	20	0	27.5	-2.5	0.981	0.5	0.4	0	38.3	51.2	0	116	147	0	27	28
2025	11	6	19	30	0	28.4	-1.1	0.981	0.5	0.5	0	37.8	51.2	0	116	147	0	28	28
2025	11	6	19	40	0	27.8	-1.7	0.981	0.5	0.4	0	38.7	51.6	0	117	148	0	27	28
2025	11	6	19	50	0	28.8	-1	0.981	0.4	0.3	0	38.7	51.6	0	117	148	0	27	28
2025	11	6	20	0	0	28.7	-1.7	0.981	0.5	0.4	0	38.7	51.6	0	117	148	0	27	28
2025	11	6	20	10	0	28.7	-1.4	0.981	0.4	0.3	0	38.3	51.6	0	117	148	0	28	28
2025	11	6	20	20	0	28	-1.6	0.981	0.4	0.3	0	38.7	51.6	0	117	148	0	27	28
2025	11	6	20	30	0	27.8	-1.9	0.981	0.5	0.5	0	38.3	52.5	0	117	149	0	28	27
2025	11	6	20	40	0	28.3	-1.9	0.982	0.5	0.5	0	38.7	52.5	0	117	149	0	27	27
2025	11	6	20	50	0	28	-1.9	0.983	0.5	0.4	0	38.3	52	0	117	149	0	28	28
2025	11	6	21	0	0	28.6	-2.2	0.983	0.5	0.5	0	38.7	52	0	118	149	0	28	28
2025	11	6	21	10	0	28.8	-1.7	0.984	0.4	0.3	0	38.7	52	0	118	149	0	28	28
2025	11	6	21	20	0	27.9	-0.7	0.984	0.4	0.3	0	38.7	52	0	117	149	0	27	28
2025	11	6	21	30	0	29.4	-2.3	0.984	0.5	0.4	0	38.7	52	0	118	149	0	28	28
2025	11	6	21	40	0	28.3	-2.6	0.984	0.4	0.3	0	38.3	52	0	117	149	0	28	28
2025	11	6	21	50	0	29.1	-1.6	0.984	0.4	0.3	0	38.7	52	0	118	149	0	28	28
2025	11	6	22	0	0	28.6	-1.1	0.984	0.4	0.3	0	39.1	52.5	0	118	149	0	27	27
2025	11	6	22	10	0	28.1	-1.3	0.984	0.4	0.3	0	38.7	52.5	0	118	150	0	28	28
2025	11	6	22	20	0	26.9	-2.1	0.984	0.6	0.5	0	39.1	52.5	0	118	150	0	27	28
2025	11	6	22	30	0	28.6	-2.2	0.984	0.4	0.3	0	39.1	52.5	0	118	150	0	27	28
2025	11	6	22	40	0	28.2	-2.1	0.984	0.4	0.3	0	38.7	52	0	118	149	0	28	28
2025	11	6	22	50	0	28.4	-1.2	0.984	0.5	0.4	0	38.7	52.9	0	118	150	0	28	27
2025	11	6	23	0	0	27.5	-2.1	0.984	0.5	0.4	0	39.1	52.5	0	118	150	0	27	28
2025	11	6	23	10	0	29.1	-1.9	0.984	0.4	0.3	0	38.7	52	0	117	150	0	27	29
2025	11	6	23	20	0	28.8	-1.6	0.984	0.3	0.2	0	38.7	52.9	0	118	150	0	28	27
2025	11	6	23	30	0	28.7	-1.8	0.984	0.3	0.2	0	38.7	52	0	117	149	0	27	28
2025	11	6	23	40	0	27.4	-2.1	0.984	0.5	0.5	0	38.7	52.5	0	118	150	0	28	28
2025	11	6	23	50	0	28.9	-1.6	0.984	0.5	0.5	0	38.3	52	0	117	149	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	7	0	0	0	28.7	-0.8	0.984	0.5	0.4	0	38.7	52.5	0	118	150	0	28	28
2025	11	7	0	10	0	27.8	-1.7	0.984	0.5	0.4	0	38.7	52	0	117	149	0	27	28
2025	11	7	0	20	0	27.7	-2	0.984	0.4	0.3	0	38.7	52.9	0	117	150	0	27	27
2025	11	7	0	30	0	29.1	-2.4	0.984	0.5	0.4	0	38.7	52	0	117	149	0	27	28
2025	11	7	0	40	0	28.3	-1.4	0.984	0.5	0.4	0	38.3	52.5	0	117	150	0	28	28
2025	11	7	0	50	0	27.9	-1.5	0.984	0.3	0.2	0	38.3	52.5	0	117	150	0	28	28
2025	11	7	1	0	0	28.2	-1.7	0.984	0.3	0.2	0	38.7	52.5	0	118	150	0	28	28
2025	11	7	1	10	0	28.8	-2	0.984	0.4	0.3	0	38.7	52.5	0	117	150	0	27	28
2025	11	7	1	20	0	27.1	-1.3	0.984	0.5	0.4	0	37.8	52	0	117	149	0	29	28
2025	11	7	1	30	0	28.4	-1.2	0.984	0.5	0.4	0	38.3	52.9	0	117	150	0	28	27
2025	11	7	1	40	0	28.3	-0.9	0.984	0.5	0.4	0	38.7	52	0	117	149	0	27	28
2025	11	7	1	50	0	28.2	-2	0.984	0.4	0.3	0	38.3	52	0	117	149	0	28	28
2025	11	7	2	0	0	29.1	-1.7	0.984	0.4	0.3	0	38.3	52.5	0	117	150	0	28	28
2025	11	7	2	10	0	28.7	-0.9	0.984	0.3	0.2	0	38.3	52.5	0	117	150	0	28	28
2025	11	7	2	20	0	28.1	-1.7	0.984	0.5	0.5	0	38.3	52	0	117	149	0	28	28
2025	11	7	2	30	0	28.3	-2.3	0.984	0.5	0.5	0	38.3	52	0	117	149	0	28	28
2025	11	7	2	40	0	28.5	-2.1	0.984	0.5	0.5	0	38.3	52	0	117	149	0	28	28
2025	11	7	2	50	0	28.6	-2.1	0.984	0.3	0.2	0	38.3	52	0	117	149	0	28	28
2025	11	7	3	0	0	27.5	-1.3	0.984	0.5	0.4	0	38.7	52	0	117	149	0	27	28
2025	11	7	3	10	0	28.2	-2.1	0.984	0.5	0.4	0	37.8	52	0	116	149	0	28	28
2025	11	7	3	20	0	29.3	-2	0.984	0.5	0.4	0	37.8	52	0	116	149	0	28	28
2025	11	7	3	30	0	28.2	-1.9	0.984	0.4	0.3	0	37.8	52	0	116	149	0	28	28
2025	11	7	3	40	0	28.2	-1.6	0.984	0.5	0.5	0	37.8	51.6	0	116	149	0	28	29
2025	11	7	3	50	0	28.1	-1.8	0.984	0.4	0.3	0	38.7	52	0	117	149	0	27	28
2025	11	7	4	0	0	27.9	-0.9	0.984	0.5	0.4	0	38.3	52	0	117	149	0	28	28
2025	11	7	4	10	0	29.3	-2.3	0.984	0.4	0.3	0	38.3	52	0	116	149	0	27	28
2025	11	7	4	20	0	28.2	-2.9	0.984	0.4	0.3	0	37.8	52	0	116	149	0	28	28
2025	11	7	4	30	0	27.8	-0.8	0.984	0.5	0.4	0	37.8	52	0	116	149	0	28	28
2025	11	7	4	40	0	27.7	-2.5	0.984	0.5	0.5	0	38.3	51.6	0	117	149	0	28	29
2025	11	7	4	50	0	28.8	-2	0.984	0.4	0.3	0	38.3	52	0	116	149	0	27	28
2025	11	7	5	0	0	28.5	-1.7	0.984	0.5	0.4	0	37.8	51.6	0	116	149	0	28	29
2025	11	7	5	10	0	28	-1.8	0.984	0.5	0.4	0	38.3	52	0	116	149	0	27	28
2025	11	7	5	20	0	28.6	-1.5	0.984	0.6	0.5	0	37.8	52	0	116	149	0	28	28
2025	11	7	5	30	0	27.3	-1.7	0.984	0.4	0.3	0	37.8	52	0	116	149	0	28	28
2025	11	7	5	40	0	28.5	-2.2	0.984	0.4	0.3	0	37.8	52	0	116	149	0	28	28
2025	11	7	5	50	0	28.2	-1.2	0.984	0.4	0.3	0	37.8	52	0	116	149	0	28	28
2025	11	7	6	0	0	29.9	-2.4	0.984	0.4	0.3	0	37.8	52	0	116	149	0	28	28
2025	11	7	6	10	0	28.8	-2.1	0.984	0.5	0.5	0	37.4	51.6	0	115	148	0	28	28
2025	11	7	6	20	0	27.8	-2.8	0.984	0.4	0.3	0	37.8	52	0	116	149	0	28	28
2025	11	7	6	30	0	28	-2.5	0.984	0.5	0.4	0	37.8	52	0	116	149	0	28	28
2025	11	7	6	40	0	29.2	-1.6	0.984	0.5	0.4	0	37.8	52	0	116	149	0	28	28
2025	11	7	6	50	0	28.8	-2.1	0.984	0.5	0.4	0	37.4	52	0	115	149	0	28	28
2025	11	7	7	0	0	28.4	-2	0.984	0.5	0.5	0	37.4	52	0	115	149	0	28	28
2025	11	7	7	10	0	28.2	-2.2	0.984	0.4	0.3	0	37.4	52	0	115	149	0	28	28
2025	11	7	7	20	0	29.3	-1.3	0.984	0.5	0.4	0	37	51.6	0	114	148	0	28	28
2025	11	7	7	30	0	28.2	-3.3	0.984	0.5	0.4	0	35.7	51.2	0	111	148	0	28	29
2025	11	7	7	40	0	28.2	-1.4	0.984	0.5	0.4	0	35.7	51.2	0	111	148	0	28	29
2025	11	7	7	50	0	27.5	-0.8	0.984	0.4	0.3	0	35.7	51.2	0	111	148	0	28	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	7	8	0	0	27.9	-1.1	0.984	0.4	0.3	0	35.3	51.2	0	110	147	0	28	28
2025	11	7	8	10	0	27.5	-2.5	0.984	0.4	0.3	0	34.8	50.3	0	109	146	0	28	29
2025	11	7	8	20	0	29.2	-2.1	0.984	0.3	0.2	0	35.3	50.7	0	109	146	0	27	28
2025	11	7	8	30	0	29.3	-1.7	0.984	0.3	0.2	0	35.3	50.3	0	109	146	0	27	29
2025	11	7	8	40	0	27.6	-2.3	0.984	0.4	0.3	0	34.8	51.2	0	108	146	0	27	27
2025	11	7	8	50	0	28.7	-3.2	0.984	0.4	0.3	0	33.5	50.3	0	106	145	0	28	28
2025	11	7	9	0	0	27.2	-1.7	0.984	0.4	0.3	0	33.5	50.3	0	106	145	0	28	28
2025	11	7	9	10	0	28.2	-2.2	0.984	0.5	0.5	0	33.5	49.5	0	105	144	0	27	29
2025	11	7	9	20	0	29.1	-1.5	0.984	0.5	0.4	0	32.7	49.5	0	104	143	0	28	28
2025	11	7	9	30	0	27.2	-1.6	0.984	0.4	0.3	0	32.7	49.5	0	105	143	0	29	28
2025	11	7	9	40	0	28.8	-1.3	0.984	0.3	0.2	0	32.7	49	0	104	142	0	28	28
2025	11	7	9	50	0	29.1	-2.3	0.984	0.4	0.3	0	32.3	49	0	103	142	0	28	28
2025	11	7	10	0	0	28.4	-1.6	0.984	0.5	0.4	0	32.3	48.6	0	103	141	0	28	28
2025	11	7	10	10	0	28.6	-2.5	0.984	0.4	0.3	0	32.7	48.2	0	103	141	0	27	29
2025	11	7	10	20	0	28.3	-1.5	0.984	0.5	0.4	0	31.8	47.7	0	102	140	0	28	29
2025	11	7	10	30	0	28.8	-1.7	0.984	0.5	0.4	0	32.3	48.6	0	103	141	0	28	28
2025	11	7	10	40	0	29.4	-2.4	0.984	0.5	0.4	0	32.7	48.6	0	104	142	0	28	29
2025	11	7	10	50	0	28.8	-2.1	0.984	0.4	0.3	0	34.8	50.7	0	108	146	0	27	28
2025	11	7	11	0	0	28.5	-2.2	0.984	0.3	0.2	0	34	49.5	0	106	144	0	27	29
2025	11	7	11	10	0	27.7	-2.5	0.984	0.5	0.5	0	32.3	48.6	0	103	141	0	28	28
2025	11	7	11	20	0	27.6	-1.8	0.984	0.5	0.4	0	32.7	49	0	104	142	0	28	28
2025	11	7	11	30	0	27.5	-1.7	0.984	0.5	0.4	0	31.8	48.2	0	102	140	0	28	28
2025	11	7	11	40	0	28.5	-2	0.984	0.4	0.3	0	31.8	48.2	0	102	140	0	28	28
2025	11	7	11	50	0	28	-2.1	0.984	0.5	0.5	0	31.4	47.7	0	101	139	0	28	28
2025	11	7	12	0	0	27.7	-1.3	0.984	0.4	0.3	0	31.4	47.3	0	101	139	0	28	29
2025	11	7	12	10	0	28.3	-1.8	0.985	0.4	0.3	0	31.4	47.7	0	101	139	0	28	28
2025	11	7	12	20	0	29	-2.3	0.985	0.5	0.4	0	31.4	47.7	0	101	139	0	28	28
2025	11	7	12	30	0	28.5	-2.6	0.985	0.4	0.3	0	31.4	48.2	0	101	139	0	28	27
2025	11	7	12	40	0	27.7	-1.8	0.985	0.5	0.5	0	32.3	48.2	0	103	141	0	28	29
2025	11	7	12	50	0	27.4	-1.8	0.985	0.5	0.5	0	32.7	49	0	104	142	0	28	28
2025	11	7	13	0	0	28.7	-1.2	0.985	0.5	0.4	0	32.7	49	0	103	141	0	27	27
2025	11	7	13	10	0	27.9	-2.4	0.985	0.5	0.4	0	32.7	49	0	104	142	0	28	28
2025	11	7	13	20	0	28.8	-2.8	0.985	0.6	0.5	0	31.8	48.2	0	102	140	0	28	28
2025	11	7	13	30	0	28.3	-3.2	0.985	0.5	0.4	0	32.3	48.2	0	102	140	0	27	28
2025	11	7	13	40	0	28.5	-2.1	0.985	0.4	0.3	0	31.8	48.2	0	102	140	0	28	28
2025	11	7	13	50	0	28.3	-2.4	0.985	0.5	0.4	0	31.8	48.2	0	102	140	0	28	28
2025	11	7	14	0	0	28	-2.3	0.985	0.5	0.5	0	31.8	47.7	0	101	139	0	27	28
2025	11	7	14	10	0	29.4	-2.5	0.985	0.5	0.4	0	30.5	47.7	0	100	139	0	29	28
2025	11	7	14	20	0	28.5	-2.6	0.985	0.5	0.5	0	31.4	46.9	0	100	138	0	27	29
2025	11	7	14	30	0	28.6	-1.2	0.985	0.6	0.5	0	31.4	47.7	0	101	139	0	28	28
2025	11	7	14	40	0	29.2	-3.4	0.985	0.3	0.2	0	31	46.9	0	100	138	0	28	29
2025	11	7	14	50	0	28.4	-2	0.985	0.4	0.3	0	31	47.7	0	100	138	0	28	27
2025	11	7	15	0	0	28.5	-2.1	0.985	0.4	0.3	0	31.4	47.7	0	100	139	0	27	28
2025	11	7	15	10	0	27.9	-2.1	0.985	0.4	0.3	0	32.7	48.6	0	103	141	0	27	28
2025	11	7	15	20	0	28.4	-1.5	0.985	0.4	0.3	0	31.8	48.6	0	102	141	0	28	28
2025	11	7	15	30	0	28	-1.1	0.985	0.4	0.3	0	31.4	47.7	0	101	139	0	28	28
2025	11	7	15	40	0	27.9	-1.8	0.985	0.5	0.5	0	31.4	48.2	0	101	140	0	28	28
2025	11	7	15	50	0	27.4	-2	0.985	0.4	0.3	0	31.8	48.2	0	101	140	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	7	16	0	0	28.2	-1.5	0.985	0.3	0.2	0	31.4	48.2	0	101	140	0	28	28
2025	11	7	16	10	0	28.1	-2	0.985	0.4	0.3	0	31.8	48.2	0	102	140	0	28	28
2025	11	7	16	20	0	28.8	-1.6	0.985	0.5	0.4	0	31.4	48.2	0	100	140	0	27	28
2025	11	7	16	30	0	28.1	-1.3	0.985	0.5	0.4	0	31.4	48.2	0	101	140	0	28	28
2025	11	7	16	40	0	27.8	-1.7	0.985	0.4	0.3	0	31.4	48.2	0	100	140	0	27	28
2025	11	7	16	50	0	28	-1.4	0.985	0.3	0.2	0	31.4	48.2	0	100	140	0	27	28
2025	11	7	17	0	0	27.7	-2.1	0.985	0.5	0.4	0	31.4	48.2	0	100	140	0	27	28
2025	11	7	17	10	0	28.4	-2.3	0.985	0.4	0.3	0	30.1	48.2	0	98	139	0	28	27
2025	11	7	17	20	0	29.7	-1.2	0.986	0.4	0.3	0	31	48.2	0	99	140	0	27	28
2025	11	7	17	30	0	27.6	-1.7	0.986	0.4	0.3	0	30.5	48.6	0	99	141	0	28	28
2025	11	7	17	40	0	29.4	-1	0.986	0.4	0.3	0	30.5	48.6	0	99	141	0	28	28
2025	11	7	17	50	0	27.3	-2.1	0.986	0.4	0.3	0	31.4	48.6	0	100	141	0	27	28
2025	11	7	18	0	0	28.6	-2.1	0.986	0.5	0.4	0	30.5	48.6	0	99	141	0	28	28
2025	11	7	18	10	0	29.3	-2.1	0.986	0.5	0.4	0	31	48.6	0	100	141	0	28	28
2025	11	7	18	20	0	27.7	-2.2	0.986	0.5	0.4	0	31.4	49	0	101	142	0	28	28
2025	11	7	18	30	0	28.3	-1.9	0.986	0.4	0.3	0	31.4	49	0	101	142	0	28	28
2025	11	7	18	40	0	29	-2.1	0.986	0.5	0.4	0	31.4	49	0	101	142	0	28	28
2025	11	7	18	50	0	29.3	-1.9	0.986	0.4	0.3	0	31.8	49	0	101	143	0	27	29
2025	11	7	19	0	0	27.3	-1.3	0.986	0.5	0.4	0	31.8	49.5	0	102	144	0	28	29
2025	11	7	19	10	0	28.8	-0.9	0.986	0.5	0.5	0	31.8	49.9	0	102	144	0	28	28
2025	11	7	19	20	0	29.4	-2.8	0.986	0.5	0.4	0	31.8	49.9	0	102	144	0	28	28
2025	11	7	19	30	0	28.5	-1.6	0.986	0.4	0.3	0	32.3	50.3	0	103	145	0	28	28
2025	11	7	19	40	0	29.1	-1.6	0.986	0.5	0.4	0	32.7	50.7	0	103	145	0	27	27
2025	11	7	19	50	0	29	-0.6	0.986	0.5	0.4	0	32.3	50.7	0	103	146	0	28	28
2025	11	7	20	0	0	28.6	-1.4	0.986	0.5	0.4	0	32.7	50.7	0	104	146	0	28	28
2025	11	7	20	10	0	30	-1.5	0.986	0.5	0.4	0	33.1	50.7	0	104	146	0	27	28
2025	11	7	20	20	0	28.4	-1.5	0.987	0.4	0.3	0	32.7	51.2	0	104	147	0	28	28
2025	11	7	20	30	0	28.1	-1.4	0.986	0.5	0.4	0	33.5	51.2	0	105	147	0	27	28
2025	11	7	20	40	0	28	-1.3	0.987	0.5	0.5	0	33.1	51.2	0	105	147	0	28	28
2025	11	7	20	50	0	28.6	-1.6	0.987	0.5	0.4	0	33.5	51.6	0	105	148	0	27	28
2025	11	7	21	0	0	28.1	-2.9	0.986	0.5	0.4	0	33.5	51.6	0	105	148	0	27	28
2025	11	7	21	10	0	28.4	-0.9	0.986	0.5	0.4	0	33.1	51.6	0	105	148	0	28	28
2025	11	7	21	20	0	29	-0.7	0.986	0.4	0.3	0	33.1	52	0	105	148	0	28	27
2025	11	7	21	30	0	28.3	-2.6	0.986	0.4	0.3	0	33.1	51.6	0	105	148	0	28	28
2025	11	7	21	40	0	28	-1.2	0.986	0.5	0.5	0	33.5	51.6	0	105	148	0	27	28
2025	11	7	21	50	0	28.2	-2.1	0.986	0.5	0.4	0	33.1	52	0	105	148	0	28	27
2025	11	7	22	0	0	28.8	-0.5	0.986	0.5	0.4	0	33.1	51.6	0	105	148	0	28	28
2025	11	7	22	10	0	28	-2.1	0.986	0.5	0.4	0	33.1	51.6	0	105	148	0	28	28
2025	11	7	22	20	0	27.3	-1.7	0.986	0.5	0.4	0	33.1	51.6	0	105	148	0	28	28
2025	11	7	22	30	0	28.7	-1.7	0.986	0.4	0.3	0	33.1	51.6	0	105	148	0	28	28
2025	11	7	22	40	0	27.9	-2.2	0.986	0.4	0.3	0	33.1	51.6	0	105	148	0	28	28
2025	11	7	22	50	0	28.2	-1.8	0.986	0.5	0.4	0	33.1	51.6	0	104	148	0	27	28
2025	11	7	23	0	0	29.4	-2.2	0.986	0.5	0.4	0	32.7	51.6	0	104	148	0	28	28
2025	11	7	23	10	0	28.2	-2.6	0.986	0.4	0.3	0	32.7	51.2	0	104	148	0	28	29
2025	11	7	23	20	0	29.1	-2.3	0.986	0.3	0.2	0	32.7	52	0	104	148	0	28	27
2025	11	7	23	30	0	28.3	-2.3	0.986	0.5	0.4	0	32.7	51.6	0	104	148	0	28	28
2025	11	7	23	40	0	27.8	-1.8	0.986	0.5	0.4	0	32.7	51.6	0	104	148	0	28	28
2025	11	7	23	50	0	27.1	-1.7	0.986	0.5	0.4	0	32.7	51.6	0	103	148	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	8	0	0	0	28.6	-1.8	0.986	0.4	0.3	0	32.3	51.6	0	103	148	0	28	28
2025	11	8	0	10	0	27.8	-1.4	0.986	0.4	0.3	0	32.7	51.6	0	104	148	0	28	28
2025	11	8	0	20	0	27.7	-1.7	0.986	0.3	0.2	0	32.3	51.6	0	103	148	0	28	28
2025	11	8	0	30	0	28.1	-2.1	0.986	0.4	0.3	0	32.3	51.6	0	103	148	0	28	28
2025	11	8	0	40	0	27.7	-1.6	0.985	0.5	0.5	0	32.3	51.6	0	103	148	0	28	28
2025	11	8	0	50	0	28.6	-1.7	0.986	0.5	0.4	0	32.3	51.2	0	103	147	0	28	28
2025	11	8	1	0	0	27.6	-1.6	0.986	0.4	0.3	0	32.7	51.6	0	103	148	0	27	28
2025	11	8	1	10	0	26.4	-1.6	0.986	0.5	0.4	0	32.7	51.6	0	103	148	0	27	28
2025	11	8	1	20	0	27.7	-1.3	0.985	0.4	0.3	0	32.7	51.2	0	103	147	0	27	28
2025	11	8	1	30	0	28.1	-1.4	0.986	0.5	0.4	0	32.3	51.6	0	103	147	0	28	27
2025	11	8	1	40	0	28.3	-2	0.985	0.4	0.3	0	32.7	51.2	0	103	147	0	27	28
2025	11	8	1	50	0	28.5	-1.5	0.985	0.5	0.4	0	32.7	51.2	0	103	147	0	27	28
2025	11	8	2	0	0	28.4	-1.9	0.985	0.5	0.4	0	32.3	51.2	0	102	147	0	27	28
2025	11	8	2	10	0	27.7	-1.4	0.985	0.5	0.5	0	32.3	50.7	0	103	147	0	28	29
2025	11	8	2	20	0	28	-2.5	0.985	0.3	0.2	0	31.4	50.7	0	101	146	0	28	28
2025	11	8	2	30	0	29	-1.9	0.985	0.4	0.3	0	31.8	50.7	0	101	146	0	27	28
2025	11	8	2	40	0	28.1	-1.7	0.985	0.4	0.3	0	31.4	50.7	0	101	146	0	28	28
2025	11	8	2	50	0	28	-1.3	0.985	0.4	0.3	0	31.4	50.7	0	101	146	0	28	28
2025	11	8	3	0	0	29	-2	0.985	0.4	0.3	0	31	50.3	0	100	145	0	28	28
2025	11	8	3	10	0	28.6	-1.3	0.985	0.3	0.2	0	31	49.9	0	100	145	0	28	29
2025	11	8	3	20	0	28.6	-1.7	0.985	0.4	0.3	0	31	49.9	0	100	145	0	28	29
2025	11	8	3	30	0	29.4	-2.4	0.985	0.3	0.2	0	31.4	50.3	0	100	145	0	27	28
2025	11	8	3	40	0	28	-2.4	0.985	0.5	0.4	0	31	50.3	0	100	145	0	28	28
2025	11	8	3	50	0	28.9	-1.7	0.985	0.4	0.3	0	31	50.3	0	100	145	0	28	28
2025	11	8	4	0	0	28.3	-2.4	0.985	0.5	0.4	0	31	49.9	0	100	145	0	28	29
2025	11	8	4	10	0	28.8	-1.7	0.985	0.3	0.2	0	31	49.9	0	100	144	0	28	28
2025	11	8	4	20	0	28.4	-2.6	0.985	0.4	0.3	0	31	49.5	0	100	144	0	28	29
2025	11	8	4	30	0	28.4	-2.1	0.985	0.5	0.4	0	30.5	49.9	0	99	144	0	28	28
2025	11	8	4	40	0	29	-1.4	0.985	0.4	0.3	0	30.5	49.5	0	99	144	0	28	29
2025	11	8	4	50	0	28	-2.5	0.985	0.4	0.3	0	30.5	49.9	0	99	144	0	28	28
2025	11	8	5	0	0	29.3	-1.9	0.985	0.5	0.4	0	30.5	49.5	0	99	144	0	28	29
2025	11	8	5	10	0	27.9	-2.5	0.985	0.5	0.4	0	31	49.5	0	99	144	0	27	29
2025	11	8	5	20	0	28.8	-2	0.985	0.5	0.4	0	30.5	49.9	0	99	144	0	28	28
2025	11	8	5	30	0	27.4	-2.2	0.985	0.5	0.5	0	30.5	49.9	0	99	144	0	28	28
2025	11	8	5	40	0	28.4	-1.8	0.985	0.4	0.3	0	30.5	49.9	0	99	144	0	28	28
2025	11	8	5	50	0	29.4	-0.8	0.985	0.4	0.3	0	30.5	49	0	99	143	0	28	29
2025	11	8	6	0	0	28.5	-2.2	0.985	0.4	0.3	0	30.5	50.3	0	99	144	0	28	27
2025	11	8	6	10	0	27.5	-1.2	0.985	0.4	0.3	0	30.5	49.5	0	99	144	0	28	29
2025	11	8	6	20	0	28.3	-3	0.985	0.5	0.4	0	30.1	49.5	0	98	143	0	28	28
2025	11	8	6	30	0	28.7	-2.3	0.985	0.5	0.4	0	30.1	49	0	98	143	0	28	29
2025	11	8	6	40	0	28.2	-2.4	0.985	0.5	0.4	0	30.5	49.5	0	98	143	0	27	28
2025	11	8	6	50	0	29.4	-2.4	0.985	0.4	0.3	0	30.1	49.5	0	98	143	0	28	28
2025	11	8	7	0	0	28.3	-2.5	0.985	0.4	0.3	0	30.1	49.5	0	98	143	0	28	28
2025	11	8	7	10	0	28.9	-2.1	0.985	0.4	0.3	0	30.1	49.5	0	98	143	0	28	28
2025	11	8	7	20	0	28.7	-1.4	0.985	0.5	0.4	0	29.7	48.6	0	97	142	0	28	29
2025	11	8	7	30	0	27.5	-1.3	0.985	0.5	0.5	0	29.7	49	0	97	142	0	28	28
2025	11	8	7	40	0	28.3	-1.2	0.985	0.4	0.3	0	29.2	48.2	0	96	141	0	28	29
2025	11	8	7	50	0	27.9	-1.6	0.985	0.4	0.3	0	29.7	48.6	0	96	141	0	27	28

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	8	8	0	0	29.1	-2.8	0.985	0.4	0.3	0	28.8	48.2	0	95	140	0	28	28
2025	11	8	8	10	0	28.4	-2.5	0.985	0.4	0.3	0	28.4	47.3	0	94	139	0	28	29
2025	11	8	8	20	0	27.8	-2.3	0.985	0.3	0.2	0	28.4	47.3	0	94	139	0	28	29
2025	11	8	8	30	0	28.9	-2.1	0.985	0.3	0.2	0	28.4	47.3	0	94	139	0	28	29
2025	11	8	8	40	0	28.8	-2.2	0.985	0.3	0.2	0	28.4	46.9	0	94	138	0	28	29
2025	11	8	8	50	0	28.3	-2	0.985	0.5	0.5	0	28.4	47.3	0	94	138	0	28	28
2025	11	8	9	0	0	28.1	-1.5	0.985	0.5	0.4	0	28	47.3	0	93	138	0	28	28
2025	11	8	9	10	0	28.5	-2.4	0.985	0.5	0.4	0	28	46.9	0	93	137	0	28	28
2025	11	8	9	20	0	28	-2.2	0.985	0.3	0.2	0	27.5	46.4	0	92	136	0	28	28
2025	11	8	9	30	0	26.8	-2	0.985	0.5	0.4	0	27.5	46	0	92	136	0	28	29
2025	11	8	9	40	0	27.9	-1.3	0.985	0.5	0.4	0	27.5	46.4	0	92	136	0	28	28
2025	11	8	9	50	0	28.6	-2.1	0.985	0.5	0.4	0	27.5	46.4	0	92	136	0	28	28
2025	11	8	10	0	0	27.9	-2.5	0.985	0.3	0.2	0	27.5	46	0	92	135	0	28	28
2025	11	8	10	10	0	27.4	-3.3	0.985	0.4	0.3	0	27.5	46	0	92	135	0	28	28
2025	11	8	10	20	0	27.9	-2.1	0.985	0.4	0.3	0	27.1	46	0	91	135	0	28	28
2025	11	8	10	30	0	29.5	-2.2	0.985	0.5	0.4	0	28	46.4	0	93	136	0	28	28
2025	11	8	10	40	0	28.1	-2.5	0.985	0.5	0.4	0	28	46	0	92	135	0	27	28
2025	11	8	10	50	0	29.2	-1.4	0.985	0.5	0.5	0	27.5	46	0	92	135	0	28	28
2025	11	8	11	0	0	28.1	-1.8	0.985	0.5	0.4	0	28	46	0	93	135	0	28	28
2025	11	8	11	10	0	27.9	-2.1	0.985	0.5	0.4	0	27.5	46	0	91	134	0	27	27
2025	11	8	11	20	0	27.7	-2.5	0.985	0.5	0.4	0	27.5	45.2	0	92	134	0	28	29
2025	11	8	11	30	0	26.9	-1.4	0.985	0.3	0.2	0	27.5	46	0	92	135	0	28	28
2025	11	8	11	40	0	27.8	-2	0.985	0.5	0.4	0	27.5	46	0	92	135	0	28	28
2025	11	8	11	50	0	27.2	-0.8	0.985	0.3	0.2	0	27.5	46	0	92	135	0	28	28
2025	11	8	12	0	0	28.9	-2.4	0.985	0.5	0.4	0	27.5	45.6	0	92	134	0	28	28
2025	11	8	12	10	0	28	-1.8	0.985	0.4	0.3	0	28	46.4	0	93	136	0	28	28
2025	11	8	12	20	0	29.8	-2.1	0.985	0.4	0.3	0	27.5	45.6	0	92	135	0	28	29
2025	11	8	12	30	0	27.1	-1.9	0.985	0.5	0.4	0	28	46.9	0	93	137	0	28	28
2025	11	8	12	40	0	28.2	-2.5	0.985	0.4	0.3	0	29.7	48.6	0	97	141	0	28	28
2025	11	8	12	50	0	28.3	-1.9	0.986	0.4	0.3	0	30.1	48.6	0	98	141	0	28	28
2025	11	8	13	0	0	28.1	-1.4	0.986	0.4	0.3	0	30.1	48.2	0	98	141	0	28	29
2025	11	8	13	10	0	27.3	-2.9	0.986	0.5	0.4	0	31	49	0	100	143	0	28	29
2025	11	8	13	20	0	27.3	-1.9	0.986	0.4	0.3	0	30.1	48.2	0	97	140	0	27	28
2025	11	8	13	30	0	28.8	-2.1	0.986	0.5	0.4	0	28.8	46.9	0	95	137	0	28	28
2025	11	8	13	40	0	27.5	-2.7	0.986	0.5	0.5	0	29.2	46.9	0	95	137	0	27	28
2025	11	8	13	50	0	27	-2.5	0.986	0.4	0.3	0	28.4	46.9	0	94	137	0	28	28
2025	11	8	14	0	0	27.6	-2.2	0.986	0.5	0.5	0	28	46	0	93	136	0	28	29
2025	11	8	14	10	0	27.9	-2.9	0.986	0.4	0.3	0	28.8	46.9	0	94	137	0	27	28
2025	11	8	14	20	0	28	-2.6	0.986	0.3	0.2	0	28	46	0	92	135	0	27	28
2025	11	8	14	30	0	26.8	-2	0.986	0.4	0.3	0	28.4	46.4	0	93	136	0	27	28
2025	11	8	14	40	0	27.3	-2.4	0.986	0.4	0.3	0	28	46	0	93	135	0	28	28
2025	11	8	14	50	0	26.7	-1.7	0.986	0.5	0.4	0	29.2	48.2	0	96	139	0	28	27
2025	11	8	15	0	0	27.3	-0.8	0.986	0.5	0.4	0	28.8	46.4	0	94	136	0	27	28
2025	11	8	15	10	0	28	-1.9	0.986	0.5	0.5	0	28.4	46	0	93	135	0	27	28
2025	11	8	15	20	0	28.1	-1.7	0.986	0.5	0.4	0	27.5	46	0	92	135	0	28	28
2025	11	8	15	30	0	28.4	-2.3	0.986	0.4	0.3	0	27.5	46	0	92	135	0	28	28
2025	11	8	15	40	0	28	-1.6	0.986	0.4	0.3	0	28.4	46.9	0	93	136	0	27	27
2025	11	8	15	50	0	28.6	-2.7	0.986	0.5	0.4	0	28.4	46.4	0	94	136	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	8	16	0	0	28.5	-2.6	0.986	0.5	0.4	0	28.8	47.3	0	95	138	0	28	28
2025	11	8	16	10	0	28.9	-3.1	0.986	0.4	0.3	0	28.8	47.3	0	95	138	0	28	28
2025	11	8	16	20	0	27.6	-3.3	0.986	0.5	0.5	0	28.8	46.9	0	94	137	0	27	28
2025	11	8	16	30	0	27.5	-1.3	0.986	0.3	0.2	0	28.8	46.9	0	94	137	0	27	28
2025	11	8	16	40	0	28.6	-2.4	0.986	0.4	0.3	0	28.4	46.9	0	94	137	0	28	28
2025	11	8	16	50	0	29	-2.6	0.986	0.5	0.4	0	28.4	47.3	0	94	137	0	28	27
2025	11	8	17	0	0	28.8	-2.9	0.986	0.5	0.5	0	28.8	46.9	0	94	137	0	27	28
2025	11	8	17	10	0	27.4	-2.8	0.986	0.5	0.4	0	28	46.9	0	92	137	0	27	28
2025	11	8	17	20	0	28	-1.4	0.986	0.5	0.4	0	28	47.3	0	93	138	0	28	28
2025	11	8	17	30	0	29.1	-2.3	0.986	0.5	0.4	0	28.4	47.3	0	94	138	0	28	28
2025	11	8	17	40	0	28.3	-1.8	0.986	0.4	0.3	0	28.4	47.3	0	94	138	0	28	28
2025	11	8	17	50	0	27.9	-2.5	0.986	0.4	0.3	0	28.4	47.3	0	93	138	0	27	28
2025	11	8	18	0	0	28.1	-2.1	0.986	0.5	0.5	0	28.4	47.3	0	93	138	0	27	28
2025	11	8	18	10	0	28.8	-1.9	0.986	0.4	0.3	0	28.4	47.3	0	93	138	0	27	28
2025	11	8	18	20	0	28.8	-1.6	0.986	0.5	0.4	0	28.4	47.7	0	94	139	0	28	28
2025	11	8	18	30	0	28.4	-3.4	0.986	0.3	0.2	0	29.2	48.2	0	95	140	0	27	28
2025	11	8	18	40	0	26.8	-2.3	0.986	0.5	0.4	0	29.2	48.6	0	96	140	0	28	27
2025	11	8	18	50	0	28	-1.7	0.986	0.5	0.4	0	29.7	48.6	0	96	141	0	27	28
2025	11	8	19	0	0	28.1	-2.1	0.986	0.4	0.3	0	29.7	48.6	0	96	141	0	27	28
2025	11	8	19	10	0	29.1	-0.9	0.986	0.5	0.5	0	29.7	48.6	0	96	141	0	27	28
2025	11	8	19	20	0	28	-1.3	0.986	0.5	0.4	0	29.7	49	0	97	142	0	28	28
2025	11	8	19	30	0	27.8	-1	0.986	0.4	0.3	0	29.7	49.5	0	97	143	0	28	28
2025	11	8	19	40	0	27.5	-2.6	0.986	0.4	0.3	0	29.7	49	0	97	142	0	28	28
2025	11	8	19	50	0	27.8	-1.3	0.986	0.4	0.3	0	30.1	49.5	0	97	143	0	27	28
2025	11	8	20	0	0	28.7	-2.1	0.986	0.5	0.4	0	30.1	49.5	0	98	143	0	28	28
2025	11	8	20	10	0	28.2	-1.9	0.986	0.4	0.3	0	30.5	49.9	0	99	143	0	28	27
2025	11	8	20	20	0	28.1	-1.7	0.986	0.3	0.2	0	31	50.3	0	99	144	0	27	27
2025	11	8	20	30	0	29.1	-1.9	0.986	0.3	0.2	0	31	49.9	0	99	144	0	27	28
2025	11	8	20	40	0	29	-2.1	0.986	0.5	0.4	0	30.5	49.9	0	99	144	0	28	28
2025	11	8	20	50	0	28.1	-2.1	0.986	0.5	0.4	0	31.4	50.7	0	100	145	0	27	27
2025	11	8	21	0	0	28.3	-2.1	0.986	0.4	0.3	0	31.4	50.3	0	100	145	0	27	28
2025	11	8	21	10	0	28.7	-2.3	0.986	0.4	0.3	0	31	50.3	0	100	145	0	28	28
2025	11	8	21	20	0	27.7	-2.4	0.986	0.5	0.4	0	31	49.9	0	100	145	0	28	29
2025	11	8	21	30	0	28.5	-2	0.986	0.5	0.5	0	31	50.7	0	100	145	0	28	27
2025	11	8	21	40	0	29.8	-2	0.986	0.4	0.3	0	31	50.3	0	100	145	0	28	28
2025	11	8	21	50	0	28	-0.9	0.986	0.4	0.3	0	31	50.3	0	100	145	0	28	28
2025	11	8	22	0	0	28.4	-2.5	0.986	0.5	0.4	0	31.4	50.3	0	100	145	0	27	28
2025	11	8	22	10	0	28.6	-1.4	0.986	0.5	0.4	0	31.4	50.3	0	100	145	0	27	28
2025	11	8	22	20	0	28.1	-0.4	0.985	0.5	0.4	0	31	50.3	0	100	145	0	28	28
2025	11	8	22	30	0	28.1	-1.7	0.985	0.5	0.4	0	31	50.3	0	100	145	0	28	28
2025	11	8	22	40	0	28	-1	0.985	0.4	0.3	0	31.4	50.3	0	100	145	0	27	28
2025	11	8	22	50	0	28.3	-1.7	0.985	0.5	0.4	0	31.4	50.7	0	100	146	0	27	28
2025	11	8	23	0	0	28.4	-2.1	0.985	0.4	0.3	0	31	50.3	0	100	145	0	28	28
2025	11	8	23	10	0	27.7	-2.1	0.985	0.5	0.4	0	31	50.7	0	100	146	0	28	28
2025	11	8	23	20	0	28.1	-2.7	0.985	0.5	0.4	0	31.4	50.3	0	100	145	0	27	28
2025	11	8	23	30	0	28.7	-2.3	0.985	0.5	0.4	0	31	50.3	0	100	146	0	28	29
2025	11	8	23	40	0	27.9	-1.7	0.985	0.4	0.3	0	31	49.9	0	100	145	0	28	29
2025	11	8	23	50	0	28.4	-1.6	0.985	0.5	0.4	0	31.4	50.3	0	101	145	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	9	0	0	0	27.6	-1.6	0.985	0.4	0.3	0	31.4	50.3	0	101	145	0	28	28
2025	11	9	0	10	0	27.5	-1.4	0.984	0.4	0.3	0	31.8	50.3	0	101	145	0	27	28
2025	11	9	0	20	0	29.3	-2	0.984	0.4	0.3	0	31.4	49.9	0	100	145	0	27	29
2025	11	9	0	30	0	27.6	-1.4	0.984	0.3	0.2	0	31.8	50.7	0	101	146	0	27	28
2025	11	9	0	40	0	28.5	-1.8	0.984	0.4	0.3	0	31	50.3	0	100	145	0	28	28
2025	11	9	0	50	0	28.5	-2.8	0.984	0.5	0.4	0	31	50.3	0	100	145	0	28	28
2025	11	9	1	0	0	28.6	-1.2	0.984	0.5	0.4	0	31	50.3	0	100	145	0	28	28
2025	11	9	1	10	0	27.3	-1.4	0.984	0.5	0.4	0	31	50.3	0	100	145	0	28	28
2025	11	9	1	20	0	28.9	-2.9	0.984	0.6	0.5	0	31	50.3	0	100	145	0	28	28
2025	11	9	1	30	0	28.1	-2.5	0.984	0.5	0.4	0	31.4	50.3	0	100	145	0	27	28
2025	11	9	1	40	0	28.2	-2.8	0.984	0.5	0.4	0	31	49.9	0	100	144	0	28	28
2025	11	9	1	50	0	28.2	-1.7	0.983	0.5	0.5	0	30.5	49.9	0	99	144	0	28	28
2025	11	9	2	0	0	27.7	-3	0.983	0.4	0.3	0	30.5	50.3	0	99	145	0	28	28
2025	11	9	2	10	0	27.3	-1.7	0.983	0.5	0.4	0	31	50.3	0	100	145	0	28	28
2025	11	9	2	20	0	28.2	-2.5	0.983	0.5	0.4	0	30.5	50.3	0	99	145	0	28	28
2025	11	9	2	30	0	28.4	-1.9	0.983	0.4	0.3	0	30.5	49.9	0	99	144	0	28	28
2025	11	9	2	40	0	29.4	-1.9	0.983	0.4	0.3	0	30.1	49.9	0	98	144	0	28	28
2025	11	9	2	50	0	28.8	-2.6	0.983	0.4	0.3	0	30.1	49.9	0	98	144	0	28	28
2025	11	9	3	0	0	27.7	-1.9	0.983	0.5	0.4	0	30.5	49.9	0	99	144	0	28	28
2025	11	9	3	10	0	27.2	-2.5	0.983	0.4	0.3	0	31	49.9	0	99	144	0	27	28
2025	11	9	3	20	0	27.3	-2.2	0.983	0.4	0.3	0	29.7	49.9	0	98	144	0	29	28
2025	11	9	3	30	0	27.7	-2.9	0.982	0.5	0.4	0	30.1	49.5	0	98	143	0	28	28
2025	11	9	3	40	0	27.3	-2.4	0.983	0.5	0.4	0	30.5	49.9	0	98	144	0	27	28
2025	11	9	3	50	0	28.7	-2	0.982	0.4	0.3	0	30.1	49.9	0	98	144	0	28	28
2025	11	9	4	0	0	27.5	-3.4	0.982	0.5	0.4	0	30.1	49.5	0	98	143	0	28	28
2025	11	9	4	10	0	28.3	-2.6	0.982	0.5	0.5	0	30.1	49.5	0	98	143	0	28	28
2025	11	9	4	20	0	29.5	-2.9	0.982	0.4	0.3	0	29.7	49.5	0	97	143	0	28	28
2025	11	9	4	30	0	27.2	-2.9	0.982	0.3	0.2	0	30.1	49.5	0	98	143	0	28	28
2025	11	9	4	40	0	26.9	-2.1	0.982	0.5	0.4	0	30.1	49	0	98	143	0	28	29
2025	11	9	4	50	0	27.8	-2.3	0.982	0.5	0.4	0	29.7	49	0	97	142	0	28	28
2025	11	9	5	0	0	28.3	-3.1	0.981	0.5	0.5	0	29.7	49	0	97	143	0	28	29
2025	11	9	5	10	0	28.3	-2.6	0.981	0.5	0.5	0	29.7	49.5	0	97	143	0	28	28
2025	11	9	5	20	0	27.9	-2.1	0.981	0.5	0.4	0	29.7	49	0	97	142	0	28	28
2025	11	9	5	30	0	27.4	-1.7	0.981	0.4	0.3	0	29.7	49.5	0	97	143	0	28	28
2025	11	9	5	40	0	28.4	-2.5	0.981	0.5	0.4	0	30.1	48.6	0	97	142	0	27	29
2025	11	9	5	50	0	27.1	-2.7	0.981	0.5	0.4	0	29.7	49.5	0	97	143	0	28	28
2025	11	9	6	0	0	27.2	-2.3	0.981	0.5	0.4	0	29.2	49	0	96	142	0	28	28
2025	11	9	6	10	0	28.1	-2.5	0.981	0.4	0.3	0	28.4	48.6	0	94	141	0	28	28
2025	11	9	6	20	0	27.6	-2.6	0.981	0.5	0.4	0	29.2	49	0	96	142	0	28	28
2025	11	9	6	30	0	28.5	-2.2	0.981	0.3	0.2	0	28.8	48.6	0	95	142	0	28	29
2025	11	9	6	40	0	28.1	-2.1	0.981	0.5	0.5	0	29.2	48.6	0	95	141	0	27	28
2025	11	9	6	50	0	27.6	-2.3	0.98	0.3	0.2	0	29.2	48.2	0	95	141	0	27	29
2025	11	9	7	0	0	27.9	-2.1	0.98	0.4	0.3	0	29.2	48.6	0	96	141	0	28	28
2025	11	9	7	10	0	28	-2.2	0.98	0.4	0.3	0	28.8	48.2	0	95	141	0	28	29
2025	11	9	7	20	0	28.2	-2.5	0.98	0.4	0.3	0	28.8	48.6	0	95	141	0	28	28
2025	11	9	7	30	0	28	-3.1	0.98	0.4	0.3	0	28.4	47.7	0	94	140	0	28	29
2025	11	9	7	40	0	28.6	-3.1	0.98	0.5	0.4	0	28.4	47.7	0	94	139	0	28	28
2025	11	9	7	50	0	27.6	-1.7	0.98	0.3	0.2	0	28	47.7	0	93	139	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	9	8	0	0	27.6	-3.1	0.98	0.4	0.3	0	27.5	46.9	0	92	138	0	28	29
2025	11	9	8	10	0	27.9	-1.4	0.979	0.5	0.4	0	27.1	46.9	0	91	137	0	28	28
2025	11	9	8	20	0	27.5	-1.1	0.978	0.3	0.2	0	28.4	47.3	0	93	138	0	27	28
2025	11	9	8	30	0	27.7	-2.7	0.978	0.5	0.4	0	27.5	46.9	0	92	137	0	28	28
2025	11	9	8	40	0	27.1	-1.6	0.977	0.4	0.3	0	27.5	46.9	0	92	137	0	28	28
2025	11	9	8	50	0	27.1	-2.8	0.977	0.3	0.2	0	27.5	46.4	0	91	136	0	27	28
2025	11	9	9	0	0	28	-2.5	0.977	0.5	0.4	0	26.7	46	0	90	135	0	28	28
2025	11	9	9	10	0	28	-1.8	0.976	0.4	0.3	0	26.7	46	0	90	135	0	28	28
2025	11	9	9	20	0	27.6	-2	0.976	0.5	0.4	0	27.1	46	0	90	135	0	27	28
2025	11	9	9	30	0	26.7	-2.1	0.976	0.4	0.3	0	26.2	45.6	0	89	134	0	28	28
2025	11	9	9	40	0	27.4	-1.7	0.976	0.5	0.5	0	26.2	45.6	0	89	134	0	28	28
2025	11	9	9	50	0	27.5	-1.7	0.975	0.5	0.4	0	26.2	45.2	0	89	133	0	28	28
2025	11	9	10	0	0	27.6	-1.6	0.975	0.5	0.5	0	26.7	46	0	89	134	0	27	27
2025	11	9	10	10	0	28.4	-2.3	0.975	0.5	0.4	0	26.2	44.7	0	88	133	0	27	29
2025	11	9	10	20	0	27.2	-2.6	0.975	0.5	0.4	0	26.7	45.2	0	90	133	0	28	28
2025	11	9	10	30	0	26.8	-2.1	0.975	0.4	0.3	0	26.7	45.6	0	90	134	0	28	28
2025	11	9	10	40	0	28	-2.3	0.975	0.4	0.3	0	26.2	45.2	0	89	133	0	28	28
2025	11	9	10	50	0	26.5	-3.8	0.975	0.5	0.4	0	26.2	44.7	0	89	132	0	28	28
2025	11	9	11	0	0	26.6	-3.8	0.975	0.5	0.4	0	26.2	44.7	0	89	132	0	28	28
2025	11	9	11	10	0	27.3	-2.3	0.975	0.4	0.3	0	26.2	44.7	0	89	132	0	28	28
2025	11	9	11	20	0	25.6	-3.4	0.975	0.5	0.5	0	26.2	44.3	0	89	132	0	28	29
2025	11	9	11	30	0	26.5	-2.8	0.975	0.5	0.4	0	26.2	44.7	0	89	132	0	28	28
2025	11	9	11	40	0	27	-2.8	0.975	0.5	0.4	0	25.8	44.3	0	88	132	0	28	29
2025	11	9	11	50	0	27.7	-2.2	0.975	0.5	0.4	0	25.8	44.3	0	88	132	0	28	29
2025	11	9	12	0	0	27.8	-2.9	0.975	0.5	0.4	0	26.2	44.3	0	88	132	0	27	29
2025	11	9	12	10	0	27.8	-3.1	0.975	0.3	0.2	0	25.8	44.3	0	88	132	0	28	29
2025	11	9	12	20	0	26.8	-1.9	0.975	0.4	0.3	0	25.8	44.3	0	88	132	0	28	29
2025	11	9	12	30	0	27.4	-3.2	0.975	0.5	0.4	0	26.2	45.2	0	88	132	0	27	27
2025	11	9	12	40	0	27.9	-3	0.975	0.5	0.4	0	25.4	44.7	0	87	132	0	28	28
2025	11	9	12	50	0	27.8	-1.9	0.975	0.5	0.4	0	25.4	44.7	0	88	132	0	29	28
2025	11	9	13	0	0	27.7	-1.5	0.975	0.5	0.4	0	27.5	46.4	0	92	136	0	28	28
2025	11	9	13	10	0	28	-2.3	0.975	0.3	0.2	0	26.7	44.7	0	89	132	0	27	28
2025	11	9	13	20	0	28.3	-2.2	0.975	0.5	0.4	0	25.8	45.2	0	89	133	0	29	28
2025	11	9	13	30	0	27.3	-2.2	0.975	0.5	0.4	0	26.2	44.7	0	89	133	0	28	29
2025	11	9	13	40	0	28.2	-2.5	0.975	0.5	0.4	0	26.2	44.7	0	88	132	0	27	28
2025	11	9	13	50	0	26.4	-3	0.975	0.5	0.4	0	26.2	44.7	0	89	132	0	28	28
2025	11	9	14	0	0	26.9	-2.3	0.975	0.4	0.3	0	25.8	44.7	0	88	132	0	28	28
2025	11	9	14	10	0	27.6	-3.1	0.975	0.3	0.2	0	26.2	44.7	0	88	132	0	27	28
2025	11	9	14	20	0	27.6	-2.1	0.975	0.5	0.5	0	26.2	45.2	0	89	132	0	28	27
2025	11	9	14	30	0	27.5	-2.2	0.975	0.3	0.2	0	25.8	44.7	0	88	132	0	28	28
2025	11	9	14	40	0	27.3	-1.8	0.975	0.4	0.3	0	26.2	44.7	0	88	132	0	27	28
2025	11	9	14	50	0	28.9	-1.2	0.975	0.4	0.3	0	26.7	45.6	0	90	134	0	28	28
2025	11	9	15	0	0	28.3	-1.9	0.975	0.4	0.3	0	26.7	45.2	0	89	133	0	27	28
2025	11	9	15	10	0	27.8	-1.7	0.975	0.5	0.4	0	26.2	45.2	0	88	132	0	27	27
2025	11	9	15	20	0	28.3	-2.7	0.975	0.5	0.4	0	26.2	44.7	0	89	132	0	28	28
2025	11	9	15	30	0	27.7	-2.1	0.975	0.5	0.4	0	27.1	45.6	0	90	134	0	27	28
2025	11	9	15	40	0	28.8	-2.2	0.975	0.4	0.3	0	26.7	45.2	0	90	133	0	28	28
2025	11	9	15	50	0	27.4	-1.7	0.975	0.4	0.3	0	26.7	45.2	0	90	133	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	9	16	0	0	28.4	-1.7	0.975	0.5	0.4	0	26.7	46	0	90	134	0	28	27
2025	11	9	16	10	0	28	-2.1	0.975	0.5	0.4	0	26.2	45.2	0	89	133	0	28	28
2025	11	9	16	20	0	28.2	-2.5	0.975	0.5	0.4	0	26.7	44.7	0	89	132	0	27	28
2025	11	9	16	30	0	28.7	-2	0.975	0.4	0.3	0	26.2	45.2	0	89	133	0	28	28
2025	11	9	16	40	0	27.2	-2.1	0.975	0.4	0.3	0	26.7	45.6	0	90	134	0	28	28
2025	11	9	16	50	0	28.3	-1	0.975	0.6	0.5	0	28	46.4	0	92	136	0	27	28
2025	11	9	17	0	0	28.3	-2.2	0.975	0.5	0.4	0	27.1	46	0	90	135	0	27	28
2025	11	9	17	10	0	28.3	-1	0.975	0.4	0.3	0	27.1	45.2	0	90	134	0	27	29
2025	11	9	17	20	0	27.6	-2	0.975	0.3	0.2	0	26.7	45.6	0	90	134	0	28	28
2025	11	9	17	30	0	27.9	-1.3	0.975	0.3	0.2	0	26.7	46.4	0	90	135	0	28	27
2025	11	9	17	40	0	28.2	-2.3	0.975	0.5	0.4	0	27.1	46	0	90	135	0	27	28
2025	11	9	17	50	0	28.2	-2.7	0.975	0.5	0.5	0	27.5	46	0	91	135	0	27	28
2025	11	9	18	0	0	28.3	-1.7	0.975	0.5	0.4	0	27.1	46	0	90	134	0	27	27
2025	11	9	18	10	0	27.8	-2.1	0.975	0.3	0.2	0	27.5	46	0	91	135	0	27	28
2025	11	9	18	20	0	27.6	-2.3	0.975	0.3	0.2	0	27.1	46.4	0	91	136	0	28	28
2025	11	9	18	30	0	27.9	-0.9	0.975	0.5	0.4	0	28	46.4	0	92	136	0	27	28
2025	11	9	18	40	0	28.2	-2.1	0.975	0.4	0.3	0	28	46.9	0	92	137	0	27	28
2025	11	9	18	50	0	28.2	-2.2	0.975	0.4	0.3	0	27.5	46.9	0	92	137	0	28	28
2025	11	9	19	0	0	27.8	-2.5	0.975	0.5	0.5	0	28.4	46.9	0	93	137	0	27	28
2025	11	9	19	10	0	28.3	-1.1	0.975	0.5	0.4	0	28	46.9	0	93	137	0	28	28
2025	11	9	19	20	0	28.5	-2.6	0.975	0.5	0.4	0	28.4	47.7	0	93	138	0	27	27
2025	11	9	19	30	0	28.5	-1.9	0.975	0.5	0.5	0	28	47.3	0	93	138	0	28	28
2025	11	9	19	40	0	28.4	-1.8	0.975	0.5	0.4	0	28	47.3	0	93	138	0	28	28
2025	11	9	19	50	0	28.1	-2.1	0.975	0.3	0.2	0	28.4	47.3	0	94	138	0	28	28
2025	11	9	20	0	0	27.3	-2	0.975	0.5	0.4	0	28.8	47.7	0	94	139	0	27	28
2025	11	9	20	10	0	27.5	-0.6	0.975	0.5	0.4	0	28.8	47.7	0	95	139	0	28	28
2025	11	9	20	20	0	26.9	-2.3	0.975	0.5	0.4	0	33.1	48.2	0	105	140	0	28	28
2025	11	9	20	30	0	26.5	-3.2	0.975	0.4	0.3	0	33.5	48.2	0	105	140	0	27	28
2025	11	9	20	40	0	26.5	-2.7	0.975	0.5	0.5	0	33.5	48.2	0	106	140	0	28	28
2025	11	9	20	50	0	27	-2.2	0.975	0.4	0.3	0	33.5	48.2	0	106	140	0	28	28
2025	11	9	21	0	0	27.4	-2.1	0.975	0.4	0.3	0	33.1	48.2	0	105	140	0	28	28
2025	11	9	21	10	0	26.2	-3	0.975	0.4	0.3	0	33.1	48.2	0	105	140	0	28	28
2025	11	9	21	20	0	27.9	-1.5	0.975	0.5	0.4	0	33.5	48.6	0	106	141	0	28	28
2025	11	9	21	30	0	27	-2.5	0.975	0.5	0.4	0	34	48.6	0	106	141	0	27	28
2025	11	9	21	40	0	27.4	-3.9	0.975	0.5	0.4	0	33.5	48.6	0	106	141	0	28	28
2025	11	9	21	50	0	24.9	-4.5	0.975	0.4	0.3	0	34.4	48.6	0	107	142	0	27	29
2025	11	9	22	0	0	26.1	-3.6	0.975	0.4	0.3	0	34	49	0	107	142	0	28	28
2025	11	9	22	10	0	25.9	-3.6	0.975	0.5	0.4	0	34	49	0	107	142	0	28	28
2025	11	9	22	20	0	25	-3.5	0.975	0.4	0.3	0	34	48.6	0	107	141	0	28	28
2025	11	9	22	30	0	26.6	-3.3	0.975	0.5	0.5	0	34.4	49	0	107	142	0	27	28
2025	11	9	22	40	0	25	-3.4	0.975	0.5	0.4	0	34	49	0	107	142	0	28	28
2025	11	9	22	50	0	26.3	-3.9	0.975	0.5	0.4	0	34	49	0	107	142	0	28	28
2025	11	9	23	0	0	25.4	-3.4	0.975	0.4	0.3	0	34.8	49.5	0	108	143	0	27	28
2025	11	9	23	10	0	26.5	-3.7	0.974	0.3	0.2	0	34.8	49.5	0	108	143	0	27	28
2025	11	9	23	20	0	26.3	-3.7	0.975	0.5	0.4	0	34.8	49.5	0	108	143	0	27	28
2025	11	9	23	30	0	25.4	-3.6	0.974	0.4	0.3	0	34.4	49.5	0	108	143	0	28	28
2025	11	9	23	40	0	26.1	-4.5	0.975	0.5	0.4	0	34.4	49	0	107	142	0	27	28
2025	11	9	23	50	0	26.6	-3.7	0.974	0.4	0.3	0	34.8	49	0	108	143	0	27	29

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	10	0	0	0	26.4	-2.8	0.974	0.4	0.3	0	34.4	48.6	0	108	142	0	28	29
2025	11	10	0	10	0	27	-2.8	0.974	0.4	0.3	0	34	49.5	0	107	143	0	28	28
2025	11	10	0	20	0	26.5	-2.7	0.974	0.4	0.3	0	34.4	49.5	0	108	143	0	28	28
2025	11	10	0	30	0	26.8	-2.7	0.974	0.5	0.4	0	34.4	49.5	0	108	143	0	28	28
2025	11	10	0	40	0	27.9	-4.6	0.974	0.4	0.3	0	34	49.5	0	107	143	0	28	28
2025	11	10	0	50	0	28	-3.4	0.974	0.5	0.4	0	34	49.5	0	107	143	0	28	28
2025	11	10	1	0	0	26.7	-4.2	0.974	0.5	0.5	0	34.4	49	0	107	143	0	27	29
2025	11	10	1	10	0	27.7	-2.1	0.974	0.4	0.3	0	34	49.5	0	107	143	0	28	28
2025	11	10	1	20	0	26.5	-2.6	0.974	0.5	0.4	0	34	49.5	0	107	143	0	28	28
2025	11	10	1	30	0	27.3	-2.2	0.974	0.3	0.2	0	34.4	49.9	0	108	144	0	28	28
2025	11	10	1	40	0	27.2	-2.3	0.974	0.5	0.5	0	34.4	49.5	0	108	144	0	28	29
2025	11	10	1	50	0	27.4	-2.2	0.974	0.3	0.2	0	34	49.9	0	107	144	0	28	28
2025	11	10	2	0	0	28.6	-2	0.974	0.5	0.5	0	34	49.5	0	107	143	0	28	28
2025	11	10	2	10	0	26.9	-2.4	0.974	0.4	0.3	0	34	49.5	0	107	143	0	28	28
2025	11	10	2	20	0	27.2	-2.9	0.974	0.5	0.5	0	34.4	49.5	0	107	143	0	27	28
2025	11	10	2	30	0	28.1	-3.3	0.974	0.4	0.3	0	34	49	0	107	143	0	28	29
2025	11	10	2	40	0	26.9	-3.2	0.974	0.4	0.3	0	34	49.5	0	107	143	0	28	28
2025	11	10	2	50	0	28	-2.3	0.974	0.5	0.4	0	34	49.5	0	107	143	0	28	28
2025	11	10	3	0	0	27.1	-2.1	0.974	0.5	0.4	0	33.5	49	0	106	143	0	28	29
2025	11	10	3	10	0	27.2	-2.8	0.974	0.4	0.3	0	33.5	49	0	106	142	0	28	28
2025	11	10	3	20	0	26.8	-3.6	0.974	0.4	0.3	0	34	49	0	107	143	0	28	29
2025	11	10	3	30	0	26.7	-2.8	0.974	0.5	0.4	0	34	49.5	0	106	143	0	27	28
2025	11	10	3	40	0	26.9	-2.9	0.974	0.5	0.4	0	33.5	49	0	106	142	0	28	28
2025	11	10	3	50	0	27	-2.8	0.974	0.5	0.4	0	33.5	48.6	0	106	142	0	28	29
2025	11	10	4	0	0	27.2	-3.1	0.974	0.4	0.3	0	33.1	49	0	105	142	0	28	28
2025	11	10	4	10	0	28.2	-1.9	0.974	0.5	0.4	0	33.1	48.6	0	105	142	0	28	29
2025	11	10	4	20	0	27.5	-2.5	0.973	0.4	0.3	0	33.1	48.6	0	105	141	0	28	28
2025	11	10	4	30	0	27.2	-3	0.973	0.5	0.5	0	33.1	49	0	105	142	0	28	28
2025	11	10	4	40	0	26.9	-1.9	0.973	0.5	0.4	0	33.1	49	0	105	142	0	28	28
2025	11	10	4	50	0	27.4	-3.3	0.974	0.5	0.4	0	33.1	48.6	0	105	141	0	28	28
2025	11	10	5	0	0	27.6	-2.8	0.974	0.4	0.3	0	33.1	49	0	105	142	0	28	28
2025	11	10	5	10	0	27.1	-2.1	0.974	0.5	0.4	0	33.5	49	0	105	142	0	27	28
2025	11	10	5	20	0	27	-1.5	0.974	0.5	0.4	0	33.5	49	0	105	142	0	27	28
2025	11	10	5	30	0	26.8	-1.8	0.974	0.5	0.4	0	32.7	48.6	0	104	141	0	28	28
2025	11	10	5	40	0	26.8	-2.3	0.974	0.5	0.4	0	34	48.6	0	106	141	0	27	28
2025	11	10	5	50	0	29.5	-1.9	0.974	0.5	0.4	0	33.5	48.6	0	106	141	0	28	28
2025	11	10	6	0	0	27.6	-1.5	0.974	0.4	0.3	0	33.5	48.6	0	106	141	0	28	28
2025	11	10	6	10	0	27.8	-2	0.974	0.5	0.4	0	33.5	48.6	0	106	141	0	28	28
2025	11	10	6	20	0	28.4	-1.8	0.974	0.5	0.4	0	32.7	48.2	0	105	140	0	29	28
2025	11	10	6	30	0	27.5	-2.2	0.974	0.5	0.4	0	33.1	47.7	0	105	140	0	28	29
2025	11	10	6	40	0	27.6	-2.1	0.974	0.5	0.4	0	33.1	48.2	0	105	140	0	28	28
2025	11	10	6	50	0	27.2	-1.6	0.974	0.4	0.3	0	33.1	48.2	0	105	140	0	28	28
2025	11	10	7	0	0	27.6	-3.3	0.974	0.4	0.3	0	32.7	48.2	0	104	140	0	28	28
2025	11	10	7	10	0	27.5	-1.4	0.974	0.5	0.4	0	32.7	47.3	0	104	139	0	28	29
2025	11	10	7	20	0	27.3	-2.3	0.974	0.4	0.3	0	32.7	47.7	0	104	139	0	28	28
2025	11	10	7	30	0	27.8	-2.5	0.974	0.5	0.5	0	32.7	47.7	0	104	139	0	28	28
2025	11	10	7	40	0	27.2	-1.6	0.974	0.5	0.5	0	32.3	47.3	0	103	138	0	28	28
2025	11	10	7	50	0	27.7	-2.5	0.974	0.5	0.5	0	32.3	46.9	0	103	137	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	10	8	0	0	28	-2.5	0.974	0.4	0.3	0	31.8	46.4	0	102	136	0	28	28
2025	11	10	8	10	0	28.2	-1.7	0.973	0.5	0.4	0	31.4	46	0	101	136	0	28	29
2025	11	10	8	20	0	28.1	-2.5	0.973	0.5	0.5	0	31.4	46.4	0	101	136	0	28	28
2025	11	10	8	30	0	28.2	-2.5	0.973	0.4	0.3	0	31.8	46.4	0	102	136	0	28	28
2025	11	10	8	40	0	27.9	-2.5	0.973	0.4	0.3	0	31.8	46	0	101	136	0	27	29
2025	11	10	8	50	0	27.9	-2.1	0.973	0.5	0.4	0	31.4	45.6	0	101	134	0	28	28
2025	11	10	9	0	0	28.6	-3	0.973	0.5	0.4	0	31.4	45.6	0	101	134	0	28	28
2025	11	10	9	10	0	28.2	-3.3	0.973	0.4	0.3	0	31.4	45.6	0	101	135	0	28	29
2025	11	10	9	20	0	26.6	-2.2	0.973	0.5	0.5	0	32.7	46.9	0	104	137	0	28	28
2025	11	10	9	30	0	27.4	-2.5	0.973	0.5	0.5	0	32.3	46.4	0	103	136	0	28	28
2025	11	10	9	40	0	28.2	-3.5	0.973	0.5	0.5	0	32.3	46.4	0	103	137	0	28	29
2025	11	10	9	50	0	27	-2	0.973	0.5	0.4	0	31.8	46.9	0	103	137	0	29	28
2025	11	10	10	0	0	27.8	-2.1	0.974	0.5	0.5	0	32.3	46	0	103	135	0	28	28
2025	11	10	10	10	0	27.2	-2.2	0.974	0.3	0.2	0	32.3	46.4	0	103	136	0	28	28
2025	11	10	10	20	0	28.2	-2.5	0.974	0.5	0.4	0	31.8	45.6	0	102	134	0	28	28
2025	11	10	10	30	0	27.6	-2.3	0.974	0.4	0.3	0	32.3	45.6	0	102	135	0	27	29
2025	11	10	10	40	0	26.6	-3.1	0.974	0.4	0.3	0	31	45.2	0	100	133	0	28	28
2025	11	10	10	50	0	27.9	-3.1	0.974	0.5	0.4	0	31	44.7	0	100	133	0	28	29
2025	11	10	11	0	0	26.8	-2.8	0.974	0.3	0.2	0	31	45.2	0	100	133	0	28	28
2025	11	10	11	10	0	26.6	-3	0.974	0.4	0.3	0	31	44.7	0	100	132	0	28	28
2025	11	10	11	20	0	28.2	-2.4	0.974	0.5	0.4	0	31	45.2	0	100	133	0	28	28
2025	11	10	11	30	0	26.5	-1.7	0.974	0.5	0.4	0	31.4	45.2	0	101	133	0	28	28
2025	11	10	11	40	0	27.5	-2.6	0.974	0.4	0.3	0	30.5	44.3	0	99	132	0	28	29
2025	11	10	11	50	0	26.8	-2.6	0.974	0.5	0.4	0	30.5	43.9	0	98	131	0	27	29
2025	11	10	12	0	0	27.5	-2.8	0.974	0.3	0.2	0	30.5	44.3	0	99	131	0	28	28
2025	11	10	12	10	0	27.6	-2.5	0.974	0.4	0.3	0	31	44.3	0	100	131	0	28	28
2025	11	10	12	20	0	27.6	-2.2	0.974	0.5	0.4	0	32.3	46.4	0	103	136	0	28	28
2025	11	10	12	30	0	27.2	-2	0.974	0.4	0.3	0	33.5	47.7	0	106	139	0	28	28
2025	11	10	12	40	0	28	-2.3	0.974	0.5	0.4	0	31.8	45.6	0	102	134	0	28	28
2025	11	10	12	50	0	26.5	-2.9	0.974	0.4	0.3	0	31	44.7	0	100	133	0	28	29
2025	11	10	13	0	0	27.2	-2	0.974	0.5	0.4	0	31.8	45.2	0	101	134	0	27	29
2025	11	10	13	10	0	27.6	-2.7	0.974	0.4	0.3	0	31	45.2	0	100	133	0	28	28
2025	11	10	13	20	0	28.1	-2.1	0.975	0.4	0.3	0	31.4	45.2	0	100	133	0	27	28
2025	11	10	13	30	0	26.2	-2.6	0.975	0.4	0.3	0	31	44.7	0	100	133	0	28	29
2025	11	10	13	40	0	27.7	-2	0.975	0.4	0.3	0	30.5	44.7	0	99	132	0	28	28
2025	11	10	13	50	0	27.2	-2.1	0.975	0.4	0.3	0	31	44.7	0	100	132	0	28	28
2025	11	10	14	0	0	26.9	-2.6	0.975	0.5	0.4	0	31	44.7	0	99	132	0	27	28
2025	11	10	14	10	0	27.7	-3.1	0.975	0.5	0.4	0	30.5	44.3	0	99	131	0	28	28
2025	11	10	14	20	0	26.9	-2.1	0.975	0.5	0.4	0	30.1	44.7	0	99	132	0	29	28
2025	11	10	14	30	0	28.1	-2.9	0.975	0.5	0.4	0	31	44.3	0	99	131	0	27	28
2025	11	10	14	40	0	27.2	-2.3	0.975	0.3	0.2	0	30.5	44.7	0	99	132	0	28	28
2025	11	10	14	50	0	26.4	-2.6	0.975	0.5	0.5	0	30.5	44.7	0	99	132	0	28	28
2025	11	10	15	0	0	26.8	-3.9	0.975	0.5	0.5	0	30.5	44.3	0	99	131	0	28	28
2025	11	10	15	10	0	27.8	-3	0.975	0.5	0.4	0	31	44.7	0	99	132	0	27	28
2025	11	10	15	20	0	27.3	-3.5	0.975	0.5	0.5	0	31.8	45.2	0	101	133	0	27	28
2025	11	10	15	30	0	28.1	-2.2	0.975	0.4	0.3	0	30.5	44.7	0	99	132	0	28	28
2025	11	10	15	40	0	27.5	-2.1	0.975	0.4	0.3	0	30.5	45.2	0	99	133	0	28	28
2025	11	10	15	50	0	28.9	-2.2	0.975	0.4	0.3	0	31	45.2	0	100	133	0	28	28

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	10	16	0	0	28.4	-2.9	0.975	0.5	0.4	0	30.5	44.7	0	99	132	0	28	28
2025	11	10	16	10	0	28.3	-2.2	0.975	0.4	0.3	0	31.8	45.6	0	101	134	0	27	28
2025	11	10	16	20	0	28.1	-2.3	0.976	0.4	0.3	0	31.4	45.2	0	100	133	0	27	28
2025	11	10	16	30	0	27.2	-2.6	0.976	0.5	0.4	0	31	45.2	0	100	133	0	28	28
2025	11	10	16	40	0	28.3	-2.9	0.976	0.5	0.4	0	31	45.6	0	100	134	0	28	28
2025	11	10	16	50	0	27.1	-1.7	0.976	0.5	0.4	0	31	45.2	0	100	133	0	28	28
2025	11	10	17	0	0	28.2	-1.7	0.976	0.4	0.3	0	30.1	44.7	0	98	133	0	28	29
2025	11	10	17	10	0	28.1	-1.5	0.976	0.3	0.2	0	31	45.2	0	99	133	0	27	28
2025	11	10	17	20	0	27.6	-2.1	0.976	0.5	0.4	0	31	45.6	0	100	134	0	28	28
2025	11	10	17	30	0	28.4	-1.8	0.976	0.5	0.4	0	31.4	45.6	0	100	134	0	27	28
2025	11	10	17	40	0	27.7	-1.4	0.976	0.5	0.4	0	31	46	0	100	135	0	28	28
2025	11	10	17	50	0	28.3	-2.9	0.976	0.5	0.4	0	31.4	46	0	100	135	0	27	28
2025	11	10	18	0	0	28	-2.1	0.976	0.5	0.4	0	31.4	46.4	0	101	136	0	28	28
2025	11	10	18	10	0	27.7	-2.5	0.976	0.4	0.3	0	31.4	46.4	0	101	136	0	28	28
2025	11	10	18	20	0	27.3	-2.1	0.976	0.4	0.3	0	32.7	47.3	0	103	138	0	27	28
2025	11	10	18	30	0	28.5	-2.1	0.976	0.5	0.5	0	32.7	46.9	0	104	138	0	28	29
2025	11	10	18	40	0	28.2	-3.4	0.977	0.4	0.3	0	32.7	47.7	0	104	139	0	28	28
2025	11	10	18	50	0	27.7	-1.8	0.977	0.5	0.4	0	33.1	47.7	0	105	139	0	28	28
2025	11	10	19	0	0	27.4	-1.8	0.977	0.4	0.3	0	33.5	48.2	0	105	140	0	27	28
2025	11	10	19	10	0	28.1	-1.1	0.977	0.4	0.3	0	33.5	48.2	0	106	140	0	28	28
2025	11	10	19	20	0	28.1	-2.9	0.977	0.5	0.4	0	34	48.6	0	106	140	0	27	27
2025	11	10	19	30	0	28.1	-2.8	0.977	0.5	0.4	0	34	48.6	0	106	141	0	27	28
2025	11	10	19	40	0	27.2	-2.3	0.977	0.4	0.3	0	34	48.6	0	107	141	0	28	28
2025	11	10	19	50	0	28.2	-2.6	0.978	0.5	0.5	0	34.4	49	0	107	141	0	27	27
2025	11	10	20	0	0	28.1	-1.4	0.978	0.4	0.3	0	34.4	49	0	107	142	0	27	28
2025	11	10	20	10	0	29.3	-1.6	0.978	0.5	0.4	0	34.4	48.6	0	107	142	0	27	29
2025	11	10	20	20	0	28.2	-1.8	0.978	0.5	0.4	0	34	49.5	0	107	142	0	28	27
2025	11	10	20	30	0	27.5	-1.3	0.978	0.5	0.4	0	34.4	49.5	0	108	143	0	28	28
2025	11	10	20	40	0	27.5	-1.3	0.978	0.5	0.4	0	34	49.9	0	107	143	0	28	27
2025	11	10	20	50	0	27.3	-1.6	0.978	0.4	0.3	0	34.8	49.5	0	108	143	0	27	28
2025	11	10	21	0	0	28.3	-1.9	0.978	0.4	0.3	0	34.8	49.5	0	108	143	0	27	28
2025	11	10	21	10	0	28.9	-2.4	0.978	0.4	0.3	0	34.4	49.9	0	108	144	0	28	28
2025	11	10	21	20	0	28	-2	0.979	0.5	0.5	0	34.4	49.9	0	108	144	0	28	28
2025	11	10	21	30	0	28.1	-2.5	0.979	0.5	0.4	0	34.8	49.9	0	108	144	0	27	28
2025	11	10	21	40	0	27.7	-1	0.98	0.5	0.5	0	34.8	49.9	0	109	144	0	28	28
2025	11	10	21	50	0	28	-1.7	0.981	0.5	0.4	0	34.8	49.5	0	109	144	0	28	29
2025	11	10	22	0	0	28.1	-0.8	0.982	0.4	0.3	0	35.3	49.9	0	109	144	0	27	28
2025	11	10	22	10	0	28.8	-2	0.982	0.5	0.4	0	34.8	49.9	0	108	144	0	27	28
2025	11	10	22	20	0	28.6	-2.7	0.982	0.4	0.3	0	34.8	50.3	0	109	145	0	28	28
2025	11	10	22	30	0	29.6	-1.2	0.982	0.5	0.5	0	34.8	50.3	0	109	145	0	28	28
2025	11	10	22	40	0	28.6	-1.7	0.982	0.5	0.4	0	34.8	50.3	0	109	145	0	28	28
2025	11	10	22	50	0	29	-1.7	0.982	0.6	0.5	0	34.8	49.9	0	109	145	0	28	29
2025	11	10	23	0	0	28.2	-1.3	0.983	0.4	0.3	0	34.8	50.3	0	109	145	0	28	28
2025	11	10	23	10	0	28	-1.5	0.983	0.4	0.3	0	34.4	50.3	0	109	145	0	29	28
2025	11	10	23	20	0	27.4	-2.1	0.983	0.3	0.2	0	35.3	50.7	0	110	146	0	28	28
2025	11	10	23	30	0	28.5	-0.8	0.983	0.5	0.4	0	35.3	50.7	0	110	146	0	28	28
2025	11	10	23	40	0	28.3	-2.5	0.983	0.4	0.3	0	34.8	50.7	0	109	146	0	28	28
2025	11	10	23	50	0	27.7	-1.3	0.983	0.4	0.3	0	35.3	50.7	0	109	146	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	11	0	0	0	28.6	-1.6	0.983	0.5	0.4	0	35.3	51.2	0	110	146	0	28	27
2025	11	11	0	10	0	28.2	-2.4	0.983	0.4	0.3	0	35.3	50.7	0	110	146	0	28	28
2025	11	11	0	20	0	28.7	-2	0.983	0.5	0.4	0	35.3	50.3	0	110	146	0	28	29
2025	11	11	0	30	0	28.1	-1.8	0.983	0.5	0.4	0	35.3	50.7	0	110	146	0	28	28
2025	11	11	0	40	0	28.1	-1.7	0.983	0.4	0.3	0	35.7	50.7	0	110	146	0	27	28
2025	11	11	0	50	0	27.3	-1.5	0.983	0.4	0.3	0	35.7	50.7	0	110	146	0	27	28
2025	11	11	1	0	0	27.6	-2.5	0.983	0.5	0.4	0	35.3	50.7	0	110	146	0	28	28
2025	11	11	1	10	0	28.9	-2.5	0.983	0.5	0.4	0	35.3	50.7	0	110	146	0	28	28
2025	11	11	1	20	0	29.3	-2	0.984	0.4	0.3	0	35.3	50.7	0	110	146	0	28	28
2025	11	11	1	30	0	28	-1.3	0.983	0.5	0.4	0	35.3	50.7	0	110	146	0	28	28
2025	11	11	1	40	0	28.2	-0.9	0.983	0.5	0.4	0	34.8	50.7	0	109	146	0	28	28
2025	11	11	1	50	0	28	-1.7	0.984	0.5	0.4	0	34.4	50.7	0	108	146	0	28	28
2025	11	11	2	0	0	28.1	-1.2	0.984	0.4	0.3	0	35.3	50.7	0	109	146	0	27	28
2025	11	11	2	10	0	28.3	-2.3	0.984	0.5	0.5	0	35.3	50.7	0	109	146	0	27	28
2025	11	11	2	20	0	27.5	-2.1	0.984	0.4	0.3	0	34.8	50.7	0	109	146	0	28	28
2025	11	11	2	30	0	27.3	-1.8	0.984	0.4	0.3	0	34.8	50.7	0	109	147	0	28	29
2025	11	11	2	40	0	29.7	-0.8	0.984	0.4	0.3	0	35.3	50.7	0	110	147	0	28	29
2025	11	11	2	50	0	28.1	-2.5	0.984	0.5	0.4	0	35.3	51.2	0	110	147	0	28	28
2025	11	11	3	0	0	27.8	-3.1	0.984	0.4	0.3	0	35.3	50.7	0	110	147	0	28	29
2025	11	11	3	10	0	28	-1.7	0.984	0.5	0.4	0	35.3	51.2	0	109	147	0	27	28
2025	11	11	3	20	0	28.2	-1.7	0.984	0.5	0.4	0	34.4	50.7	0	109	147	0	29	29
2025	11	11	3	30	0	28.3	-1.7	0.984	0.5	0.5	0	34.8	50.7	0	109	146	0	28	28
2025	11	11	3	40	0	27.6	-1.2	0.984	0.4	0.3	0	34.8	50.3	0	109	146	0	28	29
2025	11	11	3	50	0	28.1	-1.8	0.984	0.4	0.3	0	34.8	50.3	0	109	146	0	28	29
2025	11	11	4	0	0	28.3	-3	0.984	0.5	0.4	0	34.4	50.3	0	108	145	0	28	28
2025	11	11	4	10	0	27.4	-1.7	0.984	0.4	0.3	0	35.3	50.3	0	109	146	0	27	29
2025	11	11	4	20	0	27.8	-1.5	0.984	0.5	0.4	0	35.3	50.3	0	109	146	0	27	29
2025	11	11	4	30	0	28.3	-1.9	0.984	0.4	0.3	0	34.8	50.7	0	109	146	0	28	28
2025	11	11	4	40	0	28.5	-1.9	0.984	0.5	0.4	0	34.4	50.3	0	108	146	0	28	29
2025	11	11	4	50	0	28.3	-1.6	0.984	0.4	0.3	0	34.4	50.3	0	108	146	0	28	29
2025	11	11	5	0	0	28.8	-1.7	0.984	0.6	0.5	0	34.4	50.7	0	108	146	0	28	28
2025	11	11	5	10	0	28.3	-0.8	0.984	0.5	0.4	0	34.8	50.7	0	109	146	0	28	28
2025	11	11	5	20	0	26.8	-1.8	0.984	0.5	0.4	0	34.8	50.3	0	109	146	0	28	29
2025	11	11	5	30	0	28.2	-1.1	0.984	0.4	0.3	0	34.8	50.3	0	109	146	0	28	29
2025	11	11	5	40	0	28.7	-2.3	0.984	0.4	0.3	0	34.4	50.3	0	108	145	0	28	28
2025	11	11	5	50	0	27.6	-1.5	0.984	0.5	0.4	0	34.4	50.7	0	108	146	0	28	28
2025	11	11	6	0	0	28.4	-1.5	0.984	0.5	0.4	0	34.8	50.3	0	108	145	0	27	28
2025	11	11	6	10	0	28.3	-2.7	0.985	0.3	0.2	0	36.1	49.9	0	112	144	0	28	28
2025	11	11	6	20	0	27.5	-1.9	0.985	0.4	0.3	0	36.1	49.9	0	112	144	0	28	28
2025	11	11	6	30	0	28.8	-2	0.985	0.5	0.4	0	35.7	49.9	0	111	144	0	28	28
2025	11	11	6	40	0	27.5	-1.9	0.985	0.5	0.4	0	35.7	49.5	0	111	143	0	28	28
2025	11	11	6	50	0	27.6	-3.1	0.985	0.3	0.2	0	36.1	49	0	111	143	0	27	29
2025	11	11	7	0	0	28.9	-2.8	0.985	0.3	0.2	0	35.3	49.5	0	110	143	0	28	28
2025	11	11	7	10	0	28	-3.3	0.985	0.3	0.2	0	35.3	48.6	0	110	142	0	28	29
2025	11	11	7	20	0	29	-1	0.985	0.4	0.3	0	34.8	48.6	0	110	142	0	29	29
2025	11	11	7	30	0	28.2	-2.2	0.985	0.5	0.4	0	35.3	49	0	110	142	0	28	28
2025	11	11	7	40	0	28.7	-1.8	0.985	0.5	0.4	0	34.8	49	0	109	142	0	28	28
2025	11	11	7	50	0	28.1	-2.3	0.985	0.5	0.4	0	34.8	48.6	0	109	141	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	11	8	0	0	28.2	-2	0.985	0.3	0.2	0	34.8	48.6	0	109	141	0	28	28
2025	11	11	8	10	0	28.1	-2.1	0.985	0.4	0.3	0	34.4	47.7	0	108	140	0	28	29
2025	11	11	8	20	0	28.6	-2.1	0.985	0.5	0.4	0	34	48.2	0	107	140	0	28	28
2025	11	11	8	30	0	28.2	-1.3	0.985	0.4	0.3	0	34.4	48.2	0	108	140	0	28	28
2025	11	11	8	40	0	28.2	-2.3	0.985	0.4	0.3	0	34	47.7	0	107	139	0	28	28
2025	11	11	8	50	0	28.6	-1.6	0.985	0.4	0.3	0	34	47.3	0	107	138	0	28	28
2025	11	11	9	0	0	27.4	-1.5	0.985	0.4	0.3	0	33.5	47.3	0	106	138	0	28	28
2025	11	11	9	10	0	27.5	-1.6	0.985	0.4	0.3	0	33.5	46.9	0	106	137	0	28	28
2025	11	11	9	20	0	28	-3	0.985	0.4	0.3	0	32.7	46.9	0	104	137	0	28	28
2025	11	11	9	30	0	27.8	-1.9	0.985	0.3	0.2	0	33.1	46.4	0	105	136	0	28	28
2025	11	11	9	40	0	26.8	-2.9	0.985	0.3	0.2	0	32.3	45.6	0	103	135	0	28	29
2025	11	11	9	50	0	26.9	-3.1	0.985	0.4	0.3	0	32.7	45.6	0	104	135	0	28	29
2025	11	11	10	0	0	28.2	-2.3	0.985	0.4	0.3	0	32.3	45.6	0	103	135	0	28	29
2025	11	11	10	10	0	28.8	-2.5	0.986	0.5	0.4	0	31.8	46	0	102	135	0	28	28
2025	11	11	10	20	0	27.7	-3	0.986	0.5	0.4	0	32.3	45.6	0	103	134	0	28	28
2025	11	11	10	30	0	27.4	-2	0.986	0.4	0.3	0	31.8	45.6	0	102	134	0	28	28
2025	11	11	10	40	0	27.8	-1.9	0.985	0.3	0.2	0	31.8	45.2	0	102	134	0	28	29
2025	11	11	10	50	0	26.7	-1.9	0.986	0.5	0.4	0	31.8	45.6	0	102	134	0	28	28
2025	11	11	11	0	0	28.2	-3.7	0.985	0.4	0.3	0	31.8	45.6	0	102	134	0	28	28
2025	11	11	11	10	0	27.4	-2	0.985	0.5	0.4	0	33.1	45.6	0	104	135	0	27	29
2025	11	11	11	20	0	28.4	-2	0.985	0.5	0.4	0	32.7	45.6	0	104	135	0	28	29
2025	11	11	11	30	0	27.5	-2.8	0.986	0.4	0.3	0	32.7	46	0	104	135	0	28	28
2025	11	11	11	40	0	27.1	-2.3	0.986	0.4	0.3	0	32.3	45.6	0	103	134	0	28	28
2025	11	11	11	50	0	27.7	-2.5	0.986	0.5	0.4	0	32.7	45.2	0	103	134	0	27	29
2025	11	11	12	0	0	27.9	-3.5	0.986	0.5	0.4	0	32.3	45.6	0	103	134	0	28	28
2025	11	11	12	10	0	27.2	-3.8	0.986	0.5	0.4	0	32.3	45.2	0	103	134	0	28	29
2025	11	11	12	20	0	28.1	-2.9	0.986	0.4	0.3	0	32.3	45.2	0	103	134	0	28	29
2025	11	11	12	30	0	26.3	-3.1	0.986	0.3	0.2	0	31.8	45.6	0	103	134	0	29	28
2025	11	11	12	40	0	26.4	-2.7	0.986	0.3	0.2	0	31.4	45.2	0	102	133	0	29	28
2025	11	11	12	50	0	27.3	-3.9	0.986	0.5	0.4	0	32.7	45.2	0	103	134	0	27	29
2025	11	11	13	0	0	27.3	-3.3	0.986	0.5	0.4	0	32.7	45.6	0	103	134	0	27	28
2025	11	11	13	10	0	27	-3.9	0.986	0.5	0.4	0	32.7	46	0	104	135	0	28	28
2025	11	11	13	20	0	27.6	-3.5	0.986	0.5	0.4	0	33.1	45.6	0	104	135	0	27	29
2025	11	11	13	30	0	28.2	-2.7	0.986	0.4	0.3	0	33.5	46.4	0	106	137	0	28	29
2025	11	11	13	40	0	27.3	-3	0.986	0.4	0.3	0	33.5	47.7	0	106	139	0	28	28
2025	11	11	13	50	0	27.7	-2.6	0.987	0.5	0.5	0	34	46.9	0	106	138	0	27	29
2025	11	11	14	0	0	27.1	-3.8	0.987	0.3	0.2	0	34.4	47.3	0	107	138	0	27	28
2025	11	11	14	10	0	27.6	-3.2	0.987	0.5	0.4	0	32.7	46.4	0	104	136	0	28	28
2025	11	11	14	20	0	27.5	-3.3	0.987	0.4	0.3	0	33.1	46.4	0	105	137	0	28	29
2025	11	11	14	30	0	27.3	-3.4	0.987	0.4	0.3	0	33.5	47.3	0	106	138	0	28	28
2025	11	11	14	40	0	27.3	-3.7	0.987	0.3	0.2	0	33.5	46.9	0	106	137	0	28	28
2025	11	11	14	50	0	27	-4.1	0.987	0.4	0.3	0	32.7	46	0	104	136	0	28	29
2025	11	11	15	0	0	25.7	-2.8	0.987	0.5	0.4	0	32.7	46	0	104	136	0	28	29
2025	11	11	15	10	0	26.8	-3	0.987	0.4	0.3	0	32.3	46.4	0	103	136	0	28	28
2025	11	11	15	20	0	26.1	-3.8	0.987	0.5	0.4	0	32.3	45.6	0	102	135	0	27	29
2025	11	11	15	30	0	26.4	-4.7	0.987	0.5	0.4	0	31.8	46	0	102	135	0	28	28
2025	11	11	15	40	0	26.1	-4.5	0.987	0.5	0.5	0	31.8	45.6	0	102	135	0	28	29
2025	11	11	15	50	0	26.7	-5.2	0.987	0.5	0.4	0	31.8	45.6	0	102	134	0	28	28

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	11	16	0	0	24.9	-5.1	0.988	0.4	0.3	0	31.8	45.6	0	102	134	0	28	28
2025	11	11	16	10	0	24.8	-4.3	0.988	0.4	0.3	0	31.8	45.6	0	102	134	0	28	28
2025	11	11	16	20	0	24.8	-4.8	0.988	0.5	0.5	0	31.8	45.6	0	102	134	0	28	28
2025	11	11	16	30	0	25.9	-3.9	0.988	0.4	0.3	0	31.8	45.6	0	102	134	0	28	28
2025	11	11	16	40	0	26	-5.4	0.988	0.4	0.3	0	31.4	45.6	0	101	134	0	28	28
2025	11	11	16	50	0	25.5	-4.2	0.988	0.5	0.4	0	31.8	45.2	0	102	134	0	28	29
2025	11	11	17	0	0	25.5	-5	0.988	0.4	0.3	0	31.8	46	0	102	135	0	28	28
2025	11	11	17	10	0	25.7	-4.1	0.988	0.5	0.5	0	31.8	46	0	102	135	0	28	28
2025	11	11	17	20	0	26.2	-3.9	0.988	0.5	0.5	0	31.8	45.6	0	102	134	0	28	28
2025	11	11	17	30	0	26.9	-3.9	0.988	0.4	0.3	0	32.3	46.4	0	103	135	0	28	27
2025	11	11	17	40	0	27.3	-3.5	0.988	0.4	0.3	0	32.3	46	0	103	135	0	28	28
2025	11	11	17	50	0	26.8	-3.2	0.988	0.5	0.4	0	32.3	46	0	103	135	0	28	28
2025	11	11	18	0	0	26.7	-3.6	0.988	0.5	0.4	0	32.3	46.4	0	103	136	0	28	28
2025	11	11	18	10	0	26.8	-2.9	0.988	0.5	0.4	0	32.7	46.9	0	104	137	0	28	28
2025	11	11	18	20	0	26.9	-2.6	0.988	0.4	0.3	0	32.7	46.9	0	104	138	0	28	29
2025	11	11	18	30	0	27.9	-2.8	0.988	0.5	0.4	0	32.7	47.3	0	104	138	0	28	28
2025	11	11	18	40	0	27.5	-2.8	0.988	0.4	0.3	0	33.1	47.7	0	105	139	0	28	28
2025	11	11	18	50	0	25.7	-3.2	0.988	0.4	0.3	0	34	47.7	0	106	139	0	27	28
2025	11	11	19	0	0	26.7	-2	0.988	0.5	0.4	0	33.5	47.7	0	106	139	0	28	28
2025	11	11	19	10	0	27	-3.8	0.989	0.5	0.5	0	34	48.2	0	106	140	0	27	28
2025	11	11	19	20	0	27.2	-3.8	0.989	0.5	0.4	0	33.5	48.2	0	106	140	0	28	28
2025	11	11	19	30	0	27.4	-4.5	0.989	0.5	0.5	0	33.5	48.6	0	106	141	0	28	28
2025	11	11	19	40	0	27.9	-4.2	0.989	0.4	0.3	0	34	48.6	0	107	141	0	28	28
2025	11	11	19	50	0	27.1	-3.8	0.989	0.5	0.4	0	34	49	0	107	142	0	28	28
2025	11	11	20	0	0	26.2	-3	0.989	0.4	0.3	0	34.4	49	0	108	142	0	28	28
2025	11	11	20	10	0	28.1	-2.7	0.989	0.3	0.2	0	34.4	49	0	108	142	0	28	28
2025	11	11	20	20	0	26.7	-3.3	0.989	0.4	0.3	0	34.4	49.5	0	108	143	0	28	28
2025	11	11	20	30	0	26.7	-3.1	0.989	0.4	0.3	0	34.4	49.5	0	108	143	0	28	28
2025	11	11	20	40	0	27.6	-2.7	0.989	0.4	0.3	0	34.4	49.9	0	108	144	0	28	28
2025	11	11	20	50	0	28.2	-2.9	0.989	0.5	0.4	0	34.4	49.5	0	108	143	0	28	28
2025	11	11	21	0	0	26.9	-2.8	0.989	0.5	0.4	0	34.8	49.9	0	109	144	0	28	28
2025	11	11	21	10	0	27.9	-1.9	0.989	0.4	0.3	0	35.3	49.9	0	109	144	0	27	28
2025	11	11	21	20	0	28.5	-2.8	0.989	0.5	0.4	0	35.3	50.3	0	110	145	0	28	28
2025	11	11	21	30	0	27.1	-2.2	0.989	0.5	0.4	0	35.3	50.3	0	110	145	0	28	28
2025	11	11	21	40	0	27.7	-3.1	0.989	0.5	0.5	0	35.3	50.3	0	110	145	0	28	28
2025	11	11	21	50	0	28.3	-1.5	0.989	0.5	0.5	0	35.3	50.7	0	110	146	0	28	28
2025	11	11	22	0	0	28	-2.6	0.989	0.5	0.4	0	36.1	50.7	0	111	146	0	27	28
2025	11	11	22	10	0	27.9	-1.9	0.989	0.4	0.3	0	36.1	50.7	0	111	146	0	27	28
2025	11	11	22	20	0	27.5	-2.8	0.989	0.5	0.4	0	36.1	50.7	0	111	146	0	27	28
2025	11	11	22	30	0	27.3	-2.3	0.989	0.5	0.5	0	35.7	51.2	0	111	147	0	28	28
2025	11	11	22	40	0	28.3	-2.5	0.99	0.5	0.4	0	36.5	51.2	0	112	147	0	27	28
2025	11	11	22	50	0	27.8	-2.1	0.99	0.3	0.2	0	36.1	51.2	0	112	147	0	28	28
2025	11	11	23	0	0	28.4	-2.2	0.99	0.5	0.4	0	36.1	51.2	0	112	147	0	28	28
2025	11	11	23	10	0	27.7	-2.2	0.99	0.4	0.3	0	36.5	51.2	0	112	147	0	27	28
2025	11	11	23	20	0	27	-2.5	0.99	0.4	0.3	0	36.5	51.2	0	112	147	0	27	28
2025	11	11	23	30	0	28.6	-1.8	0.99	0.5	0.4	0	36.1	51.2	0	112	148	0	28	29
2025	11	11	23	40	0	28.3	-2.8	0.991	0.4	0.3	0	36.1	51.2	0	112	147	0	28	28
2025	11	11	23	50	0	28	-1.8	0.991	0.4	0.3	0	36.1	51.2	0	112	147	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	12	0	0	0	27.8	-1.7	0.991	0.4	0.3	0	36.1	51.6	0	112	148	0	28	28
2025	11	12	0	10	0	29.5	-2.9	0.991	0.4	0.3	0	36.1	51.6	0	112	148	0	28	28
2025	11	12	0	20	0	28.5	-2.4	0.991	0.5	0.5	0	36.5	51.6	0	112	148	0	27	28
2025	11	12	0	30	0	28.4	-2.6	0.991	0.4	0.3	0	36.1	51.6	0	112	148	0	28	28
2025	11	12	0	40	0	27.3	-2.7	0.991	0.4	0.3	0	36.1	51.6	0	112	148	0	28	28
2025	11	12	0	50	0	27.2	-3	0.991	0.4	0.3	0	35.7	51.6	0	111	148	0	28	28
2025	11	12	1	0	0	27.7	-3.2	0.992	0.4	0.3	0	36.1	51.2	0	112	148	0	28	29
2025	11	12	1	10	0	28.4	-2.5	0.991	0.5	0.4	0	36.1	51.2	0	112	148	0	28	29
2025	11	12	1	20	0	28.1	-2.5	0.991	0.5	0.4	0	42.6	51.2	0	127	147	0	28	28
2025	11	12	1	30	0	28.7	-2	0.991	0.4	0.3	0	42.6	51.6	0	126	148	0	27	28
2025	11	12	1	40	0	28.6	-1.3	0.991	0.5	0.4	0	41.7	51.2	0	125	147	0	28	28
2025	11	12	1	50	0	29.5	-2.7	0.991	0.4	0.3	0	41.3	51.2	0	124	147	0	28	28
2025	11	12	2	0	0	27.8	-1.2	0.992	0.5	0.4	0	42.1	50.7	0	125	147	0	27	29
2025	11	12	2	10	0	28.9	-3.1	0.991	0.5	0.4	0	41.3	51.2	0	124	147	0	28	28
2025	11	12	2	20	0	27.5	-2.9	0.991	0.3	0.2	0	41.7	51.6	0	125	148	0	28	28
2025	11	12	2	30	0	28.3	-4.1	0.99	0.4	0.3	0	41.7	51.6	0	124	148	0	27	28
2025	11	12	2	40	0	27.2	-3.3	0.991	0.4	0.3	0	41.7	51.6	0	125	148	0	28	28
2025	11	12	2	50	0	27.6	-3.3	0.99	0.5	0.5	0	41.3	51.6	0	124	148	0	28	28
2025	11	12	3	0	0	27.2	-3.1	0.991	0.5	0.4	0	40.9	51.2	0	124	148	0	29	29
2025	11	12	3	10	0	27.4	-3.5	0.991	0.5	0.5	0	41.3	51.6	0	124	148	0	28	28
2025	11	12	3	20	0	29	-2.2	0.99	0.5	0.4	0	46.4	51.6	0	136	148	0	28	28
2025	11	12	3	30	0	27.9	-1.4	0.99	0.4	0.3	0	46.4	51.6	0	136	148	0	28	28
2025	11	12	3	40	0	28.3	-2.3	0.99	0.4	0.3	0	46.9	51.2	0	136	148	0	27	29
2025	11	12	3	50	0	28.4	-1.4	0.99	0.4	0.3	0	46.4	51.2	0	136	148	0	28	29
2025	11	12	4	0	0	28.1	-2.1	0.99	0.5	0.4	0	46.4	51.6	0	136	148	0	28	28
2025	11	12	4	10	0	29.2	-2.5	0.99	0.5	0.4	0	46	51.2	0	135	148	0	28	29
2025	11	12	4	20	0	28.7	-1.1	0.991	0.3	0.2	0	46	51.2	0	135	148	0	28	29
2025	11	12	4	30	0	27.9	-2.4	0.99	0.4	0.3	0	46	51.6	0	135	148	0	28	28
2025	11	12	4	40	0	27.8	-1	0.99	0.4	0.3	0	46	51.6	0	135	148	0	28	28
2025	11	12	4	50	0	29.2	-2.4	0.991	0.5	0.4	0	46	51.6	0	134	148	0	27	28
2025	11	12	5	0	0	29.6	-2.9	0.99	0.5	0.4	0	45.6	51.6	0	134	148	0	28	28
2025	11	12	5	10	0	27.4	-1.7	0.99	0.4	0.3	0	45.6	51.6	0	134	148	0	28	28
2025	11	12	5	20	0	28.5	-2.5	0.99	0.5	0.4	0	45.6	51.6	0	134	148	0	28	28
2025	11	12	5	30	0	27.9	-1.1	0.99	0.4	0.3	0	46	52	0	134	149	0	27	28
2025	11	12	5	40	0	28	-1.4	0.99	0.5	0.4	0	45.6	51.6	0	133	148	0	27	28
2025	11	12	5	50	0	27.8	-1.5	0.99	0.5	0.4	0	45.6	52	0	133	149	0	27	28
2025	11	12	6	0	0	27.9	-1.9	0.99	0.4	0.3	0	45.2	52	0	133	149	0	28	28
2025	11	12	6	10	0	27.9	-1.7	0.99	0.5	0.4	0	44.7	51.6	0	132	148	0	28	28
2025	11	12	6	20	0	29.2	-2.4	0.991	0.3	0.2	0	44.7	51.6	0	132	148	0	28	28
2025	11	12	6	30	0	29.7	-2.9	0.991	0.5	0.5	0	44.7	51.6	0	131	148	0	27	28
2025	11	12	6	40	0	29	-1.4	0.99	0.3	0.2	0	44.7	51.6	0	132	148	0	28	28
2025	11	12	6	50	0	28.6	-2	0.99	0.5	0.4	0	44.7	51.6	0	131	148	0	27	28
2025	11	12	7	0	0	29.5	-2.4	0.99	0.4	0.3	0	44.3	51.6	0	131	148	0	28	28
2025	11	12	7	10	0	28.9	-2.2	0.99	0.4	0.3	0	44.3	51.6	0	131	148	0	28	28
2025	11	12	7	20	0	29.8	-1.6	0.99	0.5	0.4	0	43.9	51.2	0	130	148	0	28	29
2025	11	12	7	30	0	27.8	-1.5	0.99	0.4	0.3	0	43.9	51.2	0	130	148	0	28	29
2025	11	12	7	40	0	28	-2	0.99	0.5	0.4	0	43.9	51.6	0	130	148	0	28	28
2025	11	12	7	50	0	28.3	-2.5	0.989	0.5	0.4	0	43.4	51.6	0	130	148	0	29	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	12	8	0	0	28	-1.6	0.989	0.4	0.3	0	43.4	51.2	0	129	147	0	28	28
2025	11	12	8	10	0	28.4	-2.3	0.989	0.3	0.2	0	43.4	51.2	0	128	147	0	27	28
2025	11	12	8	20	0	28.5	-1.9	0.989	0.5	0.5	0	43	50.7	0	128	146	0	28	28
2025	11	12	8	30	0	28	-1	0.989	0.4	0.3	0	42.1	49.9	0	126	145	0	28	29
2025	11	12	8	40	0	28	-1.9	0.988	0.5	0.4	0	42.1	50.3	0	126	145	0	28	28
2025	11	12	8	50	0	27.4	-2.2	0.989	0.5	0.4	0	41.7	49.9	0	125	144	0	28	28
2025	11	12	9	0	0	29.1	-2.5	0.989	0.4	0.3	0	41.7	49.5	0	125	143	0	28	28
2025	11	12	9	10	0	28	-2.6	0.988	0.5	0.4	0	41.7	49.5	0	124	143	0	27	28
2025	11	12	9	20	0	27.8	-1.2	0.988	0.5	0.4	0	40.9	49	0	123	143	0	28	29
2025	11	12	9	30	0	28	-2.1	0.988	0.4	0.3	0	40.9	49.9	0	123	143	0	28	27
2025	11	12	9	40	0	29.1	-2	0.988	0.4	0.3	0	40.4	49	0	122	142	0	28	28
2025	11	12	9	50	0	29.1	-2.1	0.988	0.4	0.3	0	40.9	49	0	123	142	0	28	28
2025	11	12	10	0	0	28.1	-2.3	0.988	0.5	0.4	0	40.9	48.6	0	123	142	0	28	29
2025	11	12	10	10	0	28.1	-1.6	0.988	0.5	0.5	0	40.4	49	0	122	142	0	28	28
2025	11	12	10	20	0	29.3	-1.8	0.988	0.5	0.4	0	40	48.6	0	121	141	0	28	28
2025	11	12	10	30	0	28.5	-2.4	0.988	0.3	0.2	0	40	48.6	0	121	141	0	28	28
2025	11	12	10	40	0	27.8	-1.8	0.988	0.5	0.4	0	40	49	0	121	141	0	28	27
2025	11	12	10	50	0	27.8	-1.3	0.988	0.3	0.2	0	40	48.6	0	121	141	0	28	28
2025	11	12	11	0	0	29.3	-1.3	0.988	0.3	0.2	0	40	48.2	0	120	140	0	27	28
2025	11	12	11	10	0	28.3	-2.6	0.988	0.5	0.4	0	39.6	48.2	0	120	140	0	28	28
2025	11	12	11	20	0	28.5	-1.2	0.988	0.5	0.4	0	39.1	48.2	0	119	140	0	28	28
2025	11	12	11	30	0	28.5	-2.1	0.988	0.5	0.5	0	39.1	47.7	0	119	139	0	28	28
2025	11	12	11	40	0	28.8	-2.1	0.989	0.5	0.4	0	39.1	47.7	0	119	139	0	28	28
2025	11	12	11	50	0	29	-1.8	0.989	0.5	0.4	0	38.7	47.3	0	118	138	0	28	28
2025	11	12	12	0	0	28.4	-2.2	0.989	0.5	0.4	0	38.7	47.3	0	118	138	0	28	28
2025	11	12	12	10	0	27.5	-1.8	0.989	0.4	0.3	0	38.7	47.3	0	118	138	0	28	28
2025	11	12	12	20	0	28.4	-2.1	0.989	0.5	0.4	0	38.3	47.3	0	117	138	0	28	28
2025	11	12	12	30	0	28.5	-3	0.989	0.5	0.4	0	39.1	47.3	0	118	138	0	27	28
2025	11	12	12	40	0	29	-2	0.989	0.3	0.2	0	38.3	47.3	0	117	138	0	28	28
2025	11	12	12	50	0	28.7	-1.4	0.989	0.5	0.5	0	38.3	46.9	0	117	137	0	28	28
2025	11	12	13	0	0	27.2	-2.3	0.989	0.3	0.2	0	38.3	46.4	0	117	137	0	28	29
2025	11	12	13	10	0	29.2	-2.2	0.988	0.5	0.4	0	38.3	46.9	0	117	137	0	28	28
2025	11	12	13	20	0	28.5	-3.1	0.989	0.5	0.4	0	38.3	46.4	0	117	137	0	28	29
2025	11	12	13	30	0	27.5	-3.4	0.989	0.4	0.3	0	38.3	46.9	0	116	137	0	27	28
2025	11	12	13	40	0	27.4	-1.9	0.99	0.4	0.3	0	38.3	46.9	0	117	137	0	28	28
2025	11	12	13	50	0	28.6	-3	0.989	0.3	0.2	0	38.7	47.3	0	117	138	0	27	28
2025	11	12	14	0	0	28.3	-3.7	0.989	0.5	0.5	0	38.3	46.9	0	117	137	0	28	28
2025	11	12	14	10	0	28.2	-2.6	0.99	0.5	0.4	0	38.3	47.3	0	117	138	0	28	28
2025	11	12	14	20	0	28.3	-1.8	0.989	0.4	0.3	0	38.7	47.3	0	118	138	0	28	28
2025	11	12	14	30	0	28.8	-2.4	0.989	0.5	0.4	0	39.1	48.2	0	118	139	0	27	27
2025	11	12	14	40	0	28.7	-2.8	0.989	0.4	0.3	0	38.7	46.9	0	118	138	0	28	29
2025	11	12	14	50	0	27.8	-2.5	0.989	0.5	0.4	0	38.7	47.3	0	118	138	0	28	28
2025	11	12	15	0	0	28	-1.7	0.989	0.5	0.4	0	39.1	47.7	0	119	139	0	28	28
2025	11	12	15	10	0	28.2	-2.5	0.989	0.4	0.3	0	39.1	47.3	0	119	139	0	28	29
2025	11	12	15	20	0	28.2	-2.9	0.989	0.4	0.3	0	39.1	47.7	0	119	139	0	28	28
2025	11	12	15	30	0	27.3	-2.5	0.989	0.5	0.4	0	39.1	47.3	0	119	139	0	28	29
2025	11	12	15	40	0	28.8	-1.7	0.989	0.5	0.4	0	38.7	47.7	0	118	139	0	28	28
2025	11	12	15	50	0	28.4	-3.4	0.989	0.4	0.3	0	39.1	47.7	0	118	139	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	12	16	0	0	29.2	-3.4	0.989	0.4	0.3	0	39.1	47.7	0	118	139	0	27	28
2025	11	12	16	10	0	27.7	-3.1	0.989	0.4	0.3	0	38.7	47.7	0	118	139	0	28	28
2025	11	12	16	20	0	27.4	-2.8	0.989	0.5	0.4	0	39.1	48.2	0	119	140	0	28	28
2025	11	12	16	30	0	27.1	-2.6	0.989	0.5	0.4	0	39.6	49	0	119	141	0	27	27
2025	11	12	16	40	0	28.2	-2.3	0.989	0.5	0.5	0	39.6	48.6	0	120	141	0	28	28
2025	11	12	16	50	0	28.6	-3	0.989	0.5	0.4	0	40	49	0	121	142	0	28	28
2025	11	12	17	0	0	27.9	-2.1	0.989	0.5	0.4	0	38.7	48.2	0	118	140	0	28	28
2025	11	12	17	10	0	29.3	-2.4	0.989	0.3	0.2	0	38.7	47.7	0	118	139	0	28	28
2025	11	12	17	20	0	28.8	-3.2	0.989	0.4	0.3	0	38.7	48.6	0	118	140	0	28	27
2025	11	12	17	30	0	29.2	-2.9	0.989	0.5	0.4	0	38.3	47.7	0	117	140	0	28	29
2025	11	12	17	40	0	29.5	-2.1	0.989	0.4	0.3	0	39.1	48.2	0	118	140	0	27	28
2025	11	12	17	50	0	27.7	-2.8	0.989	0.4	0.3	0	39.1	48.2	0	118	140	0	27	28
2025	11	12	18	0	0	28.9	-2.5	0.989	0.4	0.3	0	38.7	48.2	0	118	140	0	28	28
2025	11	12	18	10	0	29.1	-1.6	0.989	0.5	0.4	0	39.6	48.6	0	119	141	0	27	28
2025	11	12	18	20	0	29.4	-1.9	0.989	0.4	0.3	0	38.7	48.6	0	118	141	0	28	28
2025	11	12	18	30	0	27.8	-2.5	0.989	0.5	0.4	0	40.4	49.5	0	122	143	0	28	28
2025	11	12	18	40	0	29.4	-2.9	0.989	0.4	0.3	0	40.9	49.5	0	122	143	0	27	28
2025	11	12	18	50	0	29.3	-2.1	0.989	0.4	0.3	0	40.9	49.9	0	122	144	0	27	28
2025	11	12	19	0	0	29	-1.8	0.989	0.4	0.3	0	43.4	49.9	0	129	144	0	28	28
2025	11	12	19	10	0	28.9	-2.1	0.989	0.5	0.4	0	43.9	50.3	0	129	144	0	27	27
2025	11	12	19	20	0	28.9	-2.8	0.989	0.4	0.3	0	44.3	50.3	0	130	145	0	27	28
2025	11	12	19	30	0	29.3	-2.4	0.989	0.5	0.4	0	43.4	49.9	0	129	144	0	28	28
2025	11	12	19	40	0	28	-2.5	0.989	0.5	0.4	0	43.4	50.3	0	129	145	0	28	28
2025	11	12	19	50	0	28.4	-1.8	0.989	0.4	0.3	0	43.9	50.7	0	129	146	0	27	28
2025	11	12	20	0	0	28.8	-3.6	0.989	0.5	0.4	0	43.9	50.7	0	130	146	0	28	28
2025	11	12	20	10	0	28.4	-2.4	0.989	0.5	0.4	0	43.9	50.7	0	130	146	0	28	28
2025	11	12	20	20	0	29.2	-2.1	0.989	0.5	0.5	0	44.3	50.7	0	130	146	0	27	28
2025	11	12	20	30	0	28.8	-1.7	0.989	0.4	0.3	0	44.3	51.2	0	130	147	0	27	28
2025	11	12	20	40	0	28.6	-1.7	0.989	0.4	0.3	0	43.9	51.2	0	130	147	0	28	28
2025	11	12	20	50	0	28.1	-2.4	0.989	0.3	0.2	0	44.3	51.2	0	130	147	0	27	28
2025	11	12	21	0	0	29	-2	0.989	0.5	0.4	0	43.9	51.2	0	130	147	0	28	28
2025	11	12	21	10	0	28.8	-2.2	0.989	0.5	0.4	0	44.3	51.6	0	130	148	0	27	28
2025	11	12	21	20	0	28.2	-0.7	0.989	0.3	0.2	0	44.3	52	0	131	149	0	28	28
2025	11	12	21	30	0	27.9	-1.8	0.989	0.5	0.4	0	44.3	52	0	131	149	0	28	28
2025	11	12	21	40	0	28.2	-2.1	0.989	0.4	0.3	0	44.3	52	0	131	149	0	28	28
2025	11	12	21	50	0	27.8	-0.9	0.989	0.5	0.4	0	43.9	52	0	130	149	0	28	28
2025	11	12	22	0	0	29	-1.7	0.989	0.5	0.5	0	43.9	51.6	0	129	148	0	27	28
2025	11	12	22	10	0	29.9	-1.9	0.989	0.5	0.4	0	43.4	51.6	0	129	148	0	28	28
2025	11	12	22	20	0	27.7	-1.3	0.989	0.4	0.3	0	43.9	52	0	130	149	0	28	28
2025	11	12	22	30	0	27.9	-1.3	0.989	0.4	0.3	0	43.9	51.6	0	130	149	0	28	29
2025	11	12	22	40	0	28.3	-1.7	0.989	0.4	0.3	0	43.9	52	0	130	149	0	28	28
2025	11	12	22	50	0	29.1	-2	0.989	0.5	0.5	0	43.9	52	0	129	149	0	27	28
2025	11	12	23	0	0	29.4	-2.2	0.989	0.4	0.3	0	43.9	52	0	130	149	0	28	28
2025	11	12	23	10	0	28.5	-1.7	0.989	0.6	0.5	0	43.9	52	0	130	150	0	28	29
2025	11	12	23	20	0	28.7	-1.2	0.989	0.4	0.3	0	43.9	51.6	0	130	149	0	28	29
2025	11	12	23	30	0	29.5	-1.8	0.989	0.5	0.5	0	43.9	52	0	130	149	0	28	28
2025	11	12	23	40	0	28.7	-2.8	0.989	0.4	0.3	0	43.4	52	0	129	149	0	28	28
2025	11	12	23	50	0	28.5	-1.5	0.989	0.6	0.5	0	43.4	52.5	0	129	150	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	13	0	0	0	28.7	-0.8	0.989	0.5	0.5	0	43.4	52	0	129	149	0	28	28
2025	11	13	0	10	0	27.8	-2.5	0.989	0.4	0.3	0	43.4	51.6	0	129	149	0	28	29
2025	11	13	0	20	0	28.2	-1.6	0.989	0.5	0.4	0	43.4	52	0	129	149	0	28	28
2025	11	13	0	30	0	27.9	-1.9	0.989	0.4	0.3	0	44.3	52.5	0	130	150	0	27	28
2025	11	13	0	40	0	29	-1.7	0.989	0.4	0.3	0	43.9	52.5	0	129	150	0	27	28
2025	11	13	0	50	0	28.9	-1.4	0.989	0.4	0.3	0	43.4	52.5	0	129	150	0	28	28
2025	11	13	1	0	0	27.8	-1.8	0.99	0.4	0.3	0	43.9	52	0	129	149	0	27	28
2025	11	13	1	10	0	28.2	-1.3	0.989	0.4	0.3	0	43.4	52.5	0	129	150	0	28	28
2025	11	13	1	20	0	27.7	-2.5	0.989	0.4	0.3	0	43.9	52.9	0	129	150	0	27	27
2025	11	13	1	30	0	28.3	-2.1	0.989	0.5	0.4	0	43.4	52.5	0	129	150	0	28	28
2025	11	13	1	40	0	27.9	-1.6	0.99	0.5	0.4	0	43.4	52.5	0	129	150	0	28	28
2025	11	13	1	50	0	27.4	-1.9	0.99	0.5	0.4	0	43.4	52.5	0	129	150	0	28	28
2025	11	13	2	0	0	26.9	-1.6	0.99	0.5	0.5	0	43.4	52.9	0	129	150	0	28	27
2025	11	13	2	10	0	27.3	-2.9	0.99	0.4	0.3	0	43	52.5	0	128	150	0	28	28
2025	11	13	2	20	0	29.3	-2.6	0.99	0.5	0.4	0	43	52	0	128	150	0	28	29
2025	11	13	2	30	0	27.5	-3.1	0.991	0.5	0.4	0	43	52	0	128	150	0	28	29
2025	11	13	2	40	0	27.4	-3.2	0.991	0.5	0.5	0	43	52	0	128	150	0	28	29
2025	11	13	2	50	0	28.7	-2.9	0.991	0.5	0.4	0	42.6	51.6	0	127	149	0	28	29
2025	11	13	3	0	0	27.9	-2.5	0.991	0.4	0.3	0	42.6	52.5	0	127	150	0	28	28
2025	11	13	3	10	0	28.9	-2.2	0.991	0.4	0.3	0	42.6	52	0	127	150	0	28	29
2025	11	13	3	20	0	27.5	-1.8	0.991	0.4	0.3	0	42.1	52.5	0	127	149	0	29	27
2025	11	13	3	30	0	27.7	-2.5	0.991	0.5	0.4	0	42.6	52	0	127	149	0	28	28
2025	11	13	3	40	0	27.8	-2.5	0.991	0.4	0.3	0	43	52	0	127	149	0	27	28
2025	11	13	3	50	0	28.4	-2.4	0.991	0.3	0.2	0	42.6	52.5	0	127	150	0	28	28
2025	11	13	4	0	0	29.5	-2.4	0.991	0.5	0.4	0	43	52.9	0	128	151	0	28	28
2025	11	13	4	10	0	29.2	-0.6	0.992	0.5	0.5	0	42.1	52	0	126	150	0	28	29
2025	11	13	4	20	0	28.6	-2.8	0.992	0.5	0.4	0	42.1	52	0	126	149	0	28	28
2025	11	13	4	30	0	28.9	-2.5	0.992	0.5	0.4	0	42.6	52.5	0	126	150	0	27	28
2025	11	13	4	40	0	27.1	-2.4	0.992	0.4	0.3	0	42.1	52.5	0	126	150	0	28	28
2025	11	13	4	50	0	27.4	-1.9	0.992	0.4	0.3	0	42.6	52.5	0	126	150	0	27	28
2025	11	13	5	0	0	28.3	-1.3	0.992	0.5	0.4	0	42.1	52	0	125	150	0	27	29
2025	11	13	5	10	0	28.8	-1.7	0.992	0.5	0.4	0	41.7	52	0	125	149	0	28	28
2025	11	13	5	20	0	29.2	-2.4	0.992	0.5	0.4	0	41.7	52	0	125	150	0	28	29
2025	11	13	5	30	0	28.5	-2	0.992	0.4	0.3	0	41.7	52.5	0	125	150	0	28	28
2025	11	13	5	40	0	28.6	-1.3	0.992	0.4	0.3	0	41.3	52.5	0	124	150	0	28	28
2025	11	13	5	50	0	28.3	-1.8	0.992	0.4	0.3	0	41.3	51.6	0	124	149	0	28	29
2025	11	13	6	0	0	28.8	-2.3	0.992	0.4	0.3	0	41.3	52	0	124	150	0	28	29
2025	11	13	6	10	0	30	-2	0.992	0.4	0.3	0	41.3	52.5	0	124	150	0	28	28
2025	11	13	6	20	0	28.4	-2.6	0.992	0.5	0.4	0	41.3	51.6	0	124	149	0	28	29
2025	11	13	6	30	0	28.5	-1.7	0.992	0.5	0.4	0	41.3	51.6	0	123	148	0	27	28
2025	11	13	6	40	0	28.7	-1.6	0.992	0.4	0.3	0	41.3	52	0	124	149	0	28	28
2025	11	13	6	50	0	28.1	-1.8	0.992	0.5	0.5	0	40.9	52	0	123	149	0	28	28
2025	11	13	7	0	0	28.5	-1.5	0.992	0.5	0.4	0	40.9	52	0	123	149	0	28	28
2025	11	13	7	10	0	28.1	-0.9	0.992	0.5	0.4	0	40.9	52	0	123	149	0	28	28
2025	11	13	7	20	0	28.9	-0.8	0.992	0.5	0.4	0	40.9	52	0	123	149	0	28	28
2025	11	13	7	30	0	28.1	-0.4	0.992	0.4	0.3	0	40.9	52	0	123	149	0	28	28
2025	11	13	7	40	0	27.8	-1.8	0.991	0.5	0.4	0	40	50.7	0	121	147	0	28	29
2025	11	13	7	50	0	28.9	-2.7	0.992	0.5	0.4	0	40.4	50.7	0	121	147	0	27	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	13	8	0	0	28.1	-2.6	0.992	0.5	0.4	0	39.6	51.2	0	120	147	0	28	28
2025	11	13	8	10	0	27.7	-1.4	0.991	0.5	0.4	0	40.4	51.6	0	122	148	0	28	28
2025	11	13	8	20	0	27.9	-2.2	0.99	0.5	0.4	0	40.4	51.6	0	122	148	0	28	28
2025	11	13	8	30	0	29.1	-2.3	0.99	0.4	0.3	0	40.9	51.6	0	123	149	0	28	29
2025	11	13	8	40	0	28.3	-2.5	0.989	0.3	0.2	0	40.9	51.6	0	123	148	0	28	28
2025	11	13	8	50	0	28.3	-2.3	0.989	0.4	0.3	0	41.7	52.5	0	125	150	0	28	28
2025	11	13	9	0	0	29.1	-2.1	0.989	0.4	0.3	0	42.1	53.3	0	126	151	0	28	27
2025	11	13	9	10	0	29.3	-2	0.99	0.4	0.3	0	42.1	52.5	0	125	150	0	27	28
2025	11	13	9	20	0	29.3	-2.4	0.989	0.4	0.3	0	41.7	52.5	0	124	150	0	27	28
2025	11	13	9	30	0	28.5	-2.2	0.988	0.5	0.4	0	40.4	51.6	0	122	148	0	28	28
2025	11	13	9	40	0	28.2	-2.5	0.988	0.5	0.4	0	39.1	50.3	0	119	145	0	28	28
2025	11	13	9	50	0	27.6	-2.5	0.988	0.5	0.4	0	38.7	49.9	0	118	144	0	28	28
2025	11	13	10	0	0	28.5	-3.2	0.988	0.4	0.3	0	38.7	49.9	0	118	144	0	28	28
2025	11	13	10	10	0	29	-2.4	0.988	0.4	0.3	0	38.3	49.5	0	117	143	0	28	28
2025	11	13	10	20	0	28.5	-2.7	0.988	0.5	0.4	0	38.3	49	0	117	142	0	28	28
2025	11	13	10	30	0	28.9	-3	0.987	0.5	0.4	0	38.7	49	0	117	142	0	27	28
2025	11	13	10	40	0	28.2	-2.2	0.987	0.4	0.3	0	37.4	48.6	0	115	141	0	28	28
2025	11	13	10	50	0	29.1	-3.1	0.987	0.4	0.3	0	37.4	48.6	0	115	141	0	28	28
2025	11	13	11	0	0	27.7	-1.7	0.986	0.5	0.4	0	37.8	48.6	0	116	141	0	28	28
2025	11	13	11	10	0	28.5	-2.1	0.987	0.4	0.3	0	38.3	49	0	116	142	0	27	28
2025	11	13	11	20	0	28.6	-2.6	0.986	0.5	0.4	0	37.4	48.6	0	115	141	0	28	28
2025	11	13	11	30	0	28.4	-2.5	0.986	0.4	0.3	0	37.4	49	0	115	141	0	28	27
2025	11	13	11	40	0	27.9	-1.6	0.986	0.5	0.4	0	38.7	49.5	0	118	143	0	28	28
2025	11	13	11	50	0	28.2	-2.5	0.986	0.5	0.4	0	40	50.7	0	121	146	0	28	28
2025	11	13	12	0	0	28.7	-2.7	0.984	0.5	0.5	0	39.6	50.7	0	120	145	0	28	27
2025	11	13	12	10	0	27.7	-2.9	0.985	0.5	0.5	0	40.4	50.7	0	121	147	0	27	29
2025	11	13	12	20	0	28.7	-2.4	0.986	0.4	0.3	0	40.9	50.7	0	122	147	0	27	29
2025	11	13	12	30	0	28.1	-3	0.984	0.5	0.5	0	41.3	51.6	0	124	149	0	28	29
2025	11	13	12	40	0	27.4	-2.1	0.984	0.4	0.3	0	41.3	52.9	0	124	151	0	28	28
2025	11	13	12	50	0	27.2	-1.7	0.982	0.3	0.2	0	43	53.8	0	127	153	0	27	28
2025	11	13	13	0	0	27.5	-1.9	0.982	0.5	0.4	0	43.4	54.2	0	129	154	0	28	28
2025	11	13	13	10	0	28.2	-2.5	0.982	0.5	0.5	0	43.4	54.2	0	128	154	0	27	28
2025	11	13	13	20	0	27.6	-2.1	0.982	0.3	0.2	0	43	53.8	0	128	153	0	28	28
2025	11	13	13	30	0	27.5	-2.1	0.982	0.5	0.4	0	42.6	53.8	0	127	153	0	28	28
2025	11	13	13	40	0	28	-2.4	0.979	0.5	0.5	0	43	53.8	0	127	153	0	27	28
2025	11	13	13	50	0	27.6	-1.5	0.98	0.4	0.3	0	43	54.2	0	128	154	0	28	28
2025	11	13	14	0	0	27.3	-1.4	0.98	0.4	0.3	0	42.1	53.3	0	125	152	0	27	28
2025	11	13	14	10	0	27.9	-2.6	0.978	0.5	0.4	0	41.7	52.5	0	124	150	0	27	28
2025	11	13	14	20	0	26.9	-2.1	0.978	0.5	0.4	0	40.9	52	0	123	149	0	28	28
2025	11	13	14	30	0	27.7	-1.8	0.978	0.5	0.5	0	41.3	52.9	0	124	150	0	28	27
2025	11	13	14	40	0	27.5	-2.4	0.977	0.4	0.3	0	40.9	52	0	123	149	0	28	28
2025	11	13	14	50	0	27.3	-1.3	0.977	0.5	0.4	0	40.4	51.6	0	122	148	0	28	28
2025	11	13	15	0	0	27.1	-2.3	0.976	0.4	0.3	0	40	51.2	0	121	147	0	28	28
2025	11	13	15	10	0	27.6	-2.3	0.975	0.4	0.3	0	41.3	51.6	0	123	148	0	27	28
2025	11	13	15	20	0	27.3	-1.5	0.976	0.5	0.4	0	40.4	51.2	0	121	147	0	27	28
2025	11	13	15	30	0	27.3	-2.1	0.975	0.4	0.3	0	39.6	50.7	0	120	146	0	28	28
2025	11	13	15	40	0	28.5	-2.8	0.974	0.5	0.4	0	39.6	50.7	0	119	146	0	27	28
2025	11	13	15	50	0	27.5	-1.9	0.974	0.5	0.4	0	39.1	50.3	0	119	145	0	28	28

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	13	16	0	0	26.3	-2.5	0.973	0.5	0.5	0	39.1	50.3	0	119	145	0	28	28
2025	11	13	16	10	0	28.1	-2	0.972	0.5	0.4	0	38.7	50.3	0	118	145	0	28	28
2025	11	13	16	20	0	28.1	-2.6	0.971	0.4	0.3	0	39.6	50.3	0	119	145	0	27	28
2025	11	13	16	30	0	27.1	-2.6	0.971	0.4	0.3	0	40	50.7	0	120	146	0	27	28
2025	11	13	16	40	0	27.7	-2.5	0.971	0.4	0.3	0	40	50.7	0	120	146	0	27	28
2025	11	13	16	50	0	27.3	-2.6	0.97	0.5	0.4	0	39.6	50.3	0	119	145	0	27	28
2025	11	13	17	0	0	28.3	-3	0.969	0.5	0.4	0	39.1	50.3	0	118	145	0	27	28
2025	11	13	17	10	0	26.6	-2.1	0.968	0.4	0.3	0	39.6	49.9	0	119	145	0	27	29
2025	11	13	17	20	0	27.2	-3	0.969	0.5	0.4	0	38.7	50.3	0	118	145	0	28	28
2025	11	13	17	30	0	27.8	-1.7	0.969	0.5	0.4	0	39.1	50.3	0	118	145	0	27	28
2025	11	13	17	40	0	28.1	-1.7	0.967	0.5	0.4	0	39.1	50.3	0	118	145	0	27	28
2025	11	13	17	50	0	26.8	-2.3	0.967	0.5	0.4	0	39.6	50.3	0	119	145	0	27	28
2025	11	13	18	0	0	26.3	-2.3	0.967	0.5	0.4	0	39.1	51.2	0	119	146	0	28	27
2025	11	13	18	10	0	26.5	-1.9	0.966	0.5	0.5	0	39.6	50.7	0	120	146	0	28	28
2025	11	13	18	20	0	27.4	-1.7	0.966	0.4	0.3	0	40	51.6	0	120	147	0	27	27
2025	11	13	18	30	0	27.4	-2	0.965	0.5	0.4	0	40	50.7	0	120	146	0	27	28
2025	11	13	18	40	0	27.4	-1.6	0.967	0.5	0.4	0	40	51.2	0	120	147	0	27	28
2025	11	13	18	50	0	26	-2.6	0.965	0.3	0.2	0	39.6	50.7	0	120	147	0	28	29
2025	11	13	19	0	0	27.7	-1.1	0.965	0.4	0.3	0	40	51.2	0	120	147	0	27	28
2025	11	13	19	10	0	27.2	-3	0.965	0.4	0.3	0	39.6	50.7	0	120	147	0	28	29
2025	11	13	19	20	0	26.5	-2.7	0.964	0.5	0.4	0	40.4	51.6	0	121	148	0	27	28
2025	11	13	19	30	0	26.5	-2.3	0.964	0.5	0.4	0	40.4	51.6	0	121	148	0	27	28
2025	11	13	19	40	0	26.2	-1.1	0.964	0.5	0.4	0	40.9	52	0	122	148	0	27	27
2025	11	13	19	50	0	27.1	-2.3	0.963	0.5	0.5	0	40.9	52.5	0	122	149	0	27	27
2025	11	13	20	0	0	26.9	-1.9	0.962	0.3	0.2	0	40	52	0	121	149	0	28	28
2025	11	13	20	10	0	27.1	-2.6	0.963	0.5	0.4	0	40.4	52	0	122	149	0	28	28
2025	11	13	20	20	0	27	-3.2	0.962	0.5	0.4	0	40.9	52	0	122	148	0	27	27
2025	11	13	20	30	0	26.6	-1.8	0.962	0.5	0.4	0	40.9	52	0	122	149	0	27	28
2025	11	13	20	40	0	26.6	-2.8	0.962	0.5	0.4	0	40.9	52	0	122	149	0	27	28
2025	11	13	20	50	0	26.5	-1.7	0.961	0.5	0.5	0	41.3	52.9	0	123	150	0	27	27
2025	11	13	21	0	0	26.7	-2.1	0.96	0.5	0.4	0	41.7	52	0	124	149	0	27	28
2025	11	13	21	10	0	26.6	-1.8	0.96	0.5	0.4	0	41.3	52	0	124	149	0	28	28
2025	11	13	21	20	0	27.1	-2.1	0.959	0.5	0.4	0	41.7	51.6	0	124	149	0	27	29
2025	11	13	21	30	0	26.9	-2	0.959	0.5	0.4	0	41.7	52.5	0	124	149	0	27	27
2025	11	13	21	40	0	26.1	-1.3	0.959	0.5	0.4	0	42.1	52.5	0	125	150	0	27	28
2025	11	13	21	50	0	26.4	-1.7	0.959	0.5	0.4	0	41.7	52.5	0	125	150	0	28	28
2025	11	13	22	0	0	26.9	-2.6	0.958	0.4	0.3	0	41.7	52.5	0	125	150	0	28	28
2025	11	13	22	10	0	27.3	-2	0.957	0.5	0.5	0	41.7	52.5	0	125	150	0	28	28
2025	11	13	22	20	0	26.1	-2.3	0.956	0.5	0.4	0	42.1	52.5	0	125	150	0	27	28
2025	11	13	22	30	0	26.1	-2.5	0.956	0.4	0.3	0	41.7	52.5	0	125	150	0	28	28
2025	11	13	22	40	0	26.9	-2	0.956	0.4	0.3	0	41.3	52	0	124	149	0	28	28
2025	11	13	22	50	0	27	-2.7	0.956	0.5	0.5	0	41.7	51.6	0	124	148	0	27	28
2025	11	13	23	0	0	26.7	-2.6	0.955	0.5	0.4	0	41.7	52	0	124	150	0	27	29
2025	11	13	23	10	0	27.6	-3.1	0.956	0.5	0.4	0	40.9	51.6	0	123	148	0	28	28
2025	11	13	23	20	0	26.2	-2.6	0.955	0.5	0.4	0	41.3	52	0	124	149	0	28	28
2025	11	13	23	30	0	27.2	-1.4	0.955	0.5	0.4	0	41.7	52	0	124	149	0	27	28
2025	11	13	23	40	0	26.4	-2	0.954	0.5	0.4	0	41.7	52.5	0	125	150	0	28	28
2025	11	13	23	50	0	25.9	-1.9	0.954	0.4	0.3	0	41.7	52.5	0	124	150	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	14	0	0	0	26.7	-1.1	0.953	0.4	0.3	0	41.3	52.5	0	124	150	0	28	28
2025	11	14	0	10	0	26.6	-2.6	0.953	0.5	0.4	0	41.3	52.9	0	124	150	0	28	27
2025	11	14	0	20	0	26.5	-2.2	0.953	0.5	0.4	0	41.3	52.5	0	124	150	0	28	28
2025	11	14	0	30	0	26.2	-1.3	0.953	0.5	0.4	0	42.1	52.5	0	125	150	0	27	28
2025	11	14	0	40	0	26.7	-2.4	0.953	0.5	0.4	0	41.7	52.5	0	125	150	0	28	28
2025	11	14	0	50	0	26.2	-1.4	0.954	0.5	0.4	0	42.1	52.9	0	126	151	0	28	28
2025	11	14	1	0	0	26.3	-2.6	0.953	0.4	0.3	0	42.1	53.3	0	126	152	0	28	28
2025	11	14	1	10	0	25.5	-2.2	0.953	0.5	0.4	0	42.1	53.3	0	126	152	0	28	28
2025	11	14	1	20	0	25.9	-3	0.952	0.5	0.4	0	42.6	52.9	0	126	151	0	27	28
2025	11	14	1	30	0	26.4	-2.1	0.951	0.4	0.3	0	43	53.3	0	127	152	0	27	28
2025	11	14	1	40	0	25.6	-2.6	0.951	0.4	0.3	0	42.6	53.3	0	126	152	0	27	28
2025	11	14	1	50	0	26.2	-2.9	0.951	0.4	0.3	0	43	53.3	0	127	152	0	27	28
2025	11	14	2	0	0	26.2	-1.4	0.951	0.5	0.5	0	42.1	52.9	0	126	152	0	28	29
2025	11	14	2	10	0	25.9	-2.4	0.951	0.5	0.4	0	42.6	52.9	0	126	151	0	27	28
2025	11	14	2	20	0	27.3	-2.2	0.951	0.5	0.4	0	42.1	52.9	0	125	151	0	27	28
2025	11	14	2	30	0	26.8	-1.7	0.952	0.5	0.4	0	41.7	52.5	0	125	150	0	28	28
2025	11	14	2	40	0	26.8	-1.9	0.951	0.5	0.5	0	42.1	52.9	0	125	150	0	27	27
2025	11	14	2	50	0	25.2	-3	0.951	0.4	0.3	0	41.7	52.5	0	124	150	0	27	28
2025	11	14	3	0	0	25.7	-1.6	0.951	0.5	0.4	0	41.7	52.5	0	124	150	0	27	28
2025	11	14	3	10	0	26.2	-1.9	0.951	0.5	0.5	0	41.7	52.5	0	124	150	0	27	28
2025	11	14	3	20	0	25.9	-1.3	0.951	0.5	0.4	0	41.3	52.5	0	124	150	0	28	28
2025	11	14	3	30	0	27	-2.4	0.951	0.5	0.4	0	41.3	51.6	0	124	149	0	28	29
2025	11	14	3	40	0	25.8	-2.1	0.95	0.5	0.5	0	41.3	52	0	124	149	0	28	28
2025	11	14	3	50	0	25.5	-2.4	0.95	0.5	0.4	0	41.3	52	0	124	149	0	28	28
2025	11	14	4	0	0	27	-3.2	0.949	0.5	0.4	0	41.7	52.5	0	124	149	0	27	27
2025	11	14	4	10	0	26.3	-2.5	0.95	0.5	0.4	0	41.7	52.5	0	124	150	0	27	28
2025	11	14	4	20	0	26.6	-1.7	0.95	0.5	0.4	0	40.9	52	0	124	149	0	29	28
2025	11	14	4	30	0	26.1	-2.6	0.95	0.4	0.3	0	41.3	52.5	0	124	150	0	28	28
2025	11	14	4	40	0	26.3	-1.8	0.949	0.5	0.5	0	41.3	52.5	0	124	150	0	28	28
2025	11	14	4	50	0	24.8	-1.3	0.948	0.5	0.4	0	41.3	52.5	0	124	150	0	28	28
2025	11	14	5	0	0	25.9	-1.5	0.949	0.5	0.4	0	41.3	52	0	124	150	0	28	29
2025	11	14	5	10	0	27.2	-3.1	0.949	0.5	0.4	0	41.7	52.9	0	124	150	0	27	27
2025	11	14	5	20	0	25.8	-2.1	0.948	0.5	0.5	0	41.3	52.5	0	124	150	0	28	28
2025	11	14	5	30	0	25.9	-2	0.948	0.5	0.4	0	41.3	52.5	0	124	150	0	28	28
2025	11	14	5	40	0	25.9	-2.8	0.948	0.5	0.5	0	41.3	52.5	0	124	150	0	28	28
2025	11	14	5	50	0	25.6	-1.5	0.947	0.6	0.5	0	42.1	52.5	0	125	150	0	27	28
2025	11	14	6	0	0	26.4	-2.5	0.948	0.5	0.4	0	41.7	52.5	0	125	150	0	28	28
2025	11	14	6	10	0	25.9	-2	0.947	0.5	0.4	0	41.7	52.9	0	125	151	0	28	28
2025	11	14	6	20	0	26.3	-2	0.948	0.5	0.4	0	42.1	52.9	0	125	151	0	27	28
2025	11	14	6	30	0	26.3	-2.5	0.948	0.5	0.4	0	41.7	52.5	0	125	150	0	28	28
2025	11	14	6	40	0	26	-0.4	0.948	0.5	0.4	0	41.3	52.5	0	124	150	0	28	28
2025	11	14	6	50	0	26.5	-1.4	0.947	0.5	0.5	0	41.3	52.5	0	124	150	0	28	28
2025	11	14	7	0	0	26.1	-3.3	0.947	0.3	0.2	0	41.7	52.5	0	124	150	0	27	28
2025	11	14	7	10	0	26.6	-2	0.947	0.5	0.4	0	41.3	52.5	0	124	150	0	28	28
2025	11	14	7	20	0	25.9	-1.6	0.947	0.4	0.3	0	41.3	52.9	0	124	150	0	28	27
2025	11	14	7	30	0	24.9	-2.2	0.947	0.5	0.4	0	41.3	52	0	124	149	0	28	28
2025	11	14	7	40	0	27.1	-2.5	0.946	0.5	0.4	0	40.9	52	0	123	149	0	28	28
2025	11	14	7	50	0	26.4	-2.1	0.947	0.5	0.5	0	40.9	52	0	123	149	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	14	8	0	0	25.2	-1.9	0.946	0.5	0.4	0	40.4	51.6	0	122	148	0	28	28
2025	11	14	8	10	0	27.1	-3.2	0.946	0.5	0.4	0	41.3	51.6	0	123	148	0	27	28
2025	11	14	8	20	0	25.2	-1.4	0.946	0.4	0.3	0	40.4	51.6	0	122	148	0	28	28
2025	11	14	8	30	0	26.6	-0.7	0.946	0.5	0.4	0	40.9	51.6	0	122	148	0	27	28
2025	11	14	8	40	0	26.4	-1.2	0.946	0.5	0.4	0	40.9	51.6	0	122	148	0	27	28
2025	11	14	8	50	0	26.3	-2.4	0.945	0.5	0.4	0	40	51.2	0	121	147	0	28	28
2025	11	14	9	0	0	25.9	-2.5	0.945	0.5	0.4	0	39.6	50.7	0	120	146	0	28	28
2025	11	14	9	10	0	26.3	-1.4	0.946	0.5	0.4	0	39.6	50.3	0	120	145	0	28	28
2025	11	14	9	20	0	25.2	-1.7	0.945	0.5	0.4	0	39.1	50.3	0	119	145	0	28	28
2025	11	14	9	30	0	25.4	-1.4	0.945	0.5	0.4	0	39.6	50.3	0	119	145	0	27	28
2025	11	14	9	40	0	25.7	-1.7	0.945	0.5	0.4	0	39.1	50.3	0	118	145	0	27	28
2025	11	14	9	50	0	25.8	-2.1	0.945	0.5	0.4	0	38.7	49.9	0	118	144	0	28	28
2025	11	14	10	0	0	25.2	-1.9	0.945	0.5	0.4	0	38.7	49.5	0	117	143	0	27	28
2025	11	14	10	10	0	26.5	-2.1	0.945	0.5	0.5	0	38.3	49.5	0	117	143	0	28	28
2025	11	14	10	20	0	24.5	-2	0.944	0.5	0.4	0	38.3	49.5	0	117	143	0	28	28
2025	11	14	10	30	0	25.9	-3.4	0.945	0.4	0.3	0	38.3	49	0	117	142	0	28	28
2025	11	14	10	40	0	26.3	-2	0.944	0.5	0.4	0	38.3	49	0	117	142	0	28	28
2025	11	14	10	50	0	26.1	-2.6	0.944	0.6	0.5	0	37.8	49	0	116	142	0	28	28
2025	11	14	11	0	0	25.6	-1.3	0.944	0.4	0.3	0	37.8	49	0	116	142	0	28	28
2025	11	14	11	10	0	25.9	-1.7	0.944	0.4	0.3	0	38.3	49	0	116	142	0	27	28
2025	11	14	11	20	0	26	-2.9	0.944	0.5	0.4	0	37.8	48.6	0	116	141	0	28	28
2025	11	14	11	30	0	26.4	-1.8	0.944	0.5	0.4	0	38.3	48.6	0	116	141	0	27	28
2025	11	14	11	40	0	26.4	-2.6	0.944	0.5	0.5	0	38.3	48.6	0	116	141	0	27	28
2025	11	14	11	50	0	26.2	-2.2	0.944	0.5	0.4	0	37.8	49	0	116	142	0	28	28
2025	11	14	12	0	0	25.8	-2	0.944	0.5	0.4	0	38.3	48.6	0	116	141	0	27	28
2025	11	14	12	10	0	25.9	-1.3	0.944	0.5	0.4	0	37.8	49	0	116	142	0	28	28
2025	11	14	12	20	0	25.8	-2.1	0.944	0.5	0.5	0	37.8	48.6	0	116	141	0	28	28
2025	11	14	12	30	0	26.5	-3.2	0.943	0.5	0.5	0	37.8	48.6	0	116	141	0	28	28
2025	11	14	12	40	0	26.8	-2.6	0.944	0.5	0.5	0	38.3	48.6	0	116	141	0	27	28
2025	11	14	12	50	0	26.9	-2.5	0.944	0.5	0.5	0	38.3	48.2	0	115	140	0	26	28
2025	11	14	13	0	0	25.5	-1.3	0.944	0.5	0.5	0	37.4	48.6	0	115	141	0	28	28
2025	11	14	13	10	0	26.5	-2.2	0.944	0.4	0.3	0	37.4	48.2	0	114	140	0	27	28
2025	11	14	13	20	0	26.9	-2.4	0.943	0.5	0.4	0	37.8	48.2	0	115	140	0	27	28
2025	11	14	13	30	0	25.2	-2.1	0.943	0.5	0.5	0	37.8	48.2	0	115	140	0	27	28
2025	11	14	13	40	0	26.1	-2.1	0.943	0.5	0.4	0	37.8	48.6	0	115	141	0	27	28
2025	11	14	13	50	0	26.8	-2.6	0.943	0.5	0.4	0	37.8	49	0	116	141	0	28	27
2025	11	14	14	0	0	25.2	-2.6	0.944	0.4	0.3	0	38.3	49	0	116	142	0	27	28
2025	11	14	14	10	0	25.8	-2.5	0.943	0.5	0.4	0	37.4	49	0	115	141	0	28	27
2025	11	14	14	20	0	25.5	-2.8	0.943	0.5	0.5	0	37.8	48.6	0	115	140	0	27	27
2025	11	14	14	30	0	26	-2.3	0.943	0.5	0.4	0	37	48.2	0	114	140	0	28	28
2025	11	14	14	40	0	25.7	-2.2	0.944	0.5	0.4	0	37.4	48.6	0	114	140	0	27	27
2025	11	14	14	50	0	26.6	-2.5	0.943	0.5	0.5	0	37	48.6	0	114	140	0	28	27
2025	11	14	15	0	0	26.9	-2.1	0.943	0.5	0.5	0	37	48.2	0	114	140	0	28	28
2025	11	14	15	10	0	26.5	-1.9	0.944	0.5	0.5	0	37.8	48.6	0	115	140	0	27	27
2025	11	14	15	20	0	25.9	-2.4	0.944	0.4	0.3	0	37	48.6	0	114	140	0	28	27
2025	11	14	15	30	0	26.5	-1.6	0.943	0.5	0.5	0	37.4	48.2	0	114	140	0	27	28
2025	11	14	15	40	0	26	-1.8	0.944	0.5	0.5	0	37.8	48.6	0	115	141	0	27	28
2025	11	14	15	50	0	24.8	-3.6	0.944	0.5	0.5	0	37	48.2	0	114	140	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	14	16	0	0	24.7	-2.5	0.944	0.5	0.4	0	38.3	48.6	0	116	141	0	27	28
2025	11	14	16	10	0	25.8	-3	0.944	0.5	0.5	0	38.3	48.6	0	116	141	0	27	28
2025	11	14	16	20	0	24.9	-2.4	0.944	0.4	0.3	0	37.8	48.6	0	116	141	0	28	28
2025	11	14	16	30	0	25.9	-3.4	0.944	0.5	0.4	0	37.8	48.2	0	115	140	0	27	28
2025	11	14	16	40	0	25.2	-2.9	0.944	0.3	0.2	0	37.8	48.6	0	115	141	0	27	28
2025	11	14	16	50	0	25.3	-3.3	0.944	0.6	0.5	0	37.8	48.6	0	115	140	0	27	27
2025	11	14	17	0	0	25.2	-3.4	0.944	0.5	0.4	0	38.3	48.2	0	116	141	0	27	29
2025	11	14	17	10	0	24.3	-2.4	0.944	0.5	0.5	0	37.8	48.6	0	116	141	0	28	28
2025	11	14	17	20	0	23.4	-4.4	0.944	0.3	0.2	0	38.3	48.6	0	116	141	0	27	28
2025	11	14	17	30	0	25.2	-2.8	0.944	0.5	0.5	0	37.8	48.6	0	116	141	0	28	28
2025	11	14	17	40	0	24.8	-3	0.944	0.4	0.3	0	37.8	49	0	116	142	0	28	28
2025	11	14	17	50	0	25	-2.5	0.944	0.5	0.4	0	38.3	49	0	116	142	0	27	28
2025	11	14	18	0	0	25.7	-2.1	0.944	0.5	0.4	0	38.3	49	0	116	142	0	27	28
2025	11	14	18	10	0	24.5	-3.6	0.944	0.5	0.4	0	38.7	49	0	117	142	0	27	28
2025	11	14	18	20	0	24	-3.8	0.945	0.4	0.3	0	38.7	49.9	0	118	144	0	28	28
2025	11	14	18	30	0	25.2	-3.5	0.944	0.5	0.4	0	38.7	49.9	0	118	144	0	28	28
2025	11	14	18	40	0	25.7	-3.2	0.944	0.4	0.3	0	39.1	49.9	0	118	144	0	27	28
2025	11	14	18	50	0	25.2	-3.3	0.945	0.5	0.4	0	39.1	50.3	0	119	145	0	28	28
2025	11	14	19	0	0	24.4	-3.5	0.945	0.4	0.3	0	39.6	50.7	0	119	146	0	27	28
2025	11	14	19	10	0	25.6	-2.7	0.945	0.5	0.4	0	39.6	50.3	0	119	145	0	27	28
2025	11	14	19	20	0	26.1	-2.1	0.945	0.4	0.3	0	39.1	50.3	0	119	145	0	28	28
2025	11	14	19	30	0	24.9	-3.2	0.945	0.5	0.5	0	39.1	50.3	0	119	145	0	28	28
2025	11	14	19	40	0	25.2	-2.9	0.945	0.4	0.3	0	40	50.7	0	120	146	0	27	28
2025	11	14	19	50	0	25.4	-3.2	0.945	0.5	0.4	0	40	51.2	0	120	147	0	27	28
2025	11	14	20	0	0	24.8	-2.1	0.945	0.5	0.4	0	40	51.2	0	120	147	0	27	28
2025	11	14	20	10	0	24.5	-1.3	0.945	0.6	0.5	0	39.6	50.7	0	120	146	0	28	28
2025	11	14	20	20	0	25.4	-2.4	0.945	0.3	0.2	0	39.6	51.2	0	120	147	0	28	28
2025	11	14	20	30	0	24.9	-1.3	0.945	0.5	0.5	0	40.4	51.2	0	121	147	0	27	28
2025	11	14	20	40	0	25.4	-2.4	0.945	0.5	0.4	0	40	51.2	0	121	147	0	28	28
2025	11	14	20	50	0	25.3	-2.2	0.945	0.4	0.3	0	40.4	51.2	0	121	148	0	27	29
2025	11	14	21	0	0	24.5	-2.5	0.945	0.4	0.3	0	40	51.6	0	121	148	0	28	28
2025	11	14	21	10	0	24.9	-1.6	0.944	0.5	0.5	0	40.4	51.6	0	121	148	0	27	28
2025	11	14	21	20	0	26	-3	0.944	0.5	0.4	0	40.4	51.6	0	121	148	0	27	28
2025	11	14	21	30	0	25.9	-1.9	0.944	0.5	0.5	0	40	51.6	0	121	148	0	28	28
2025	11	14	21	40	0	25.2	-2.5	0.944	0.4	0.3	0	40	51.6	0	121	148	0	28	28
2025	11	14	21	50	0	25.2	-2.6	0.944	0.6	0.5	0	40	51.6	0	121	148	0	28	28
2025	11	14	22	0	0	25.6	-2.1	0.944	0.5	0.4	0	40	51.6	0	121	147	0	28	27
2025	11	14	22	10	0	25.9	-1.1	0.944	0.5	0.4	0	40	51.6	0	120	148	0	27	28
2025	11	14	22	20	0	26	-1.5	0.944	0.4	0.3	0	40	51.6	0	120	148	0	27	28
2025	11	14	22	30	0	26.5	-2	0.944	0.5	0.4	0	40	51.6	0	121	148	0	28	28
2025	11	14	22	40	0	25.5	-2.5	0.944	0.5	0.5	0	40	51.6	0	121	148	0	28	28
2025	11	14	22	50	0	25.6	-2.1	0.944	0.4	0.3	0	40	51.6	0	121	148	0	28	28
2025	11	14	23	0	0	26.3	-0.7	0.945	0.5	0.4	0	40	52	0	121	149	0	28	28
2025	11	14	23	10	0	25.6	-1.3	0.945	0.4	0.3	0	40.4	51.6	0	121	148	0	27	28
2025	11	14	23	20	0	26.9	-3	0.945	0.5	0.5	0	41.3	52.5	0	123	149	0	27	27
2025	11	14	23	30	0	26.3	-1.5	0.945	0.4	0.3	0	41.3	51.6	0	123	149	0	27	29
2025	11	14	23	40	0	26.4	-3	0.945	0.5	0.4	0	40.9	52	0	123	149	0	28	28
2025	11	14	23	50	0	25.9	-2.2	0.945	0.5	0.4	0	41.3	52	0	123	149	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	15	0	0	0	25.9	-1.9	0.945	0.4	0.3	0	40.9	51.6	0	123	149	0	28	29
2025	11	15	0	10	0	26.4	-2.4	0.945	0.5	0.4	0	40.9	52	0	123	149	0	28	28
2025	11	15	0	20	0	25.5	-2.2	0.945	0.4	0.3	0	41.3	52.5	0	124	150	0	28	28
2025	11	15	0	30	0	25.6	-2	0.945	0.6	0.5	0	41.3	52	0	123	149	0	27	28
2025	11	15	0	40	0	25.8	-2	0.945	0.5	0.5	0	41.7	52.9	0	124	150	0	27	27
2025	11	15	0	50	0	25.3	-1.2	0.945	0.5	0.4	0	41.3	52.5	0	123	150	0	27	28
2025	11	15	1	0	0	24.4	-1.7	0.946	0.5	0.5	0	40.9	52	0	123	149	0	28	28
2025	11	15	1	10	0	25.9	-2.4	0.946	0.5	0.4	0	40.9	52	0	123	149	0	28	28
2025	11	15	1	20	0	26.8	-1.3	0.946	0.5	0.4	0	40.9	52	0	123	149	0	28	28
2025	11	15	1	30	0	25.7	-1.4	0.946	0.5	0.4	0	41.3	52	0	124	150	0	28	29
2025	11	15	1	40	0	26.3	-1.8	0.946	0.5	0.5	0	41.3	52	0	123	149	0	27	28
2025	11	15	1	50	0	26.5	-1.9	0.947	0.4	0.3	0	41.3	52	0	123	149	0	27	28
2025	11	15	2	0	0	27.1	-2.3	0.947	0.4	0.3	0	41.3	52.5	0	124	150	0	28	28
2025	11	15	2	10	0	25.7	-1.7	0.947	0.4	0.3	0	41.3	52.5	0	124	150	0	28	28
2025	11	15	2	20	0	25.2	-1.6	0.948	0.5	0.5	0	41.3	52.5	0	124	150	0	28	28
2025	11	15	2	30	0	25.1	-1.6	0.949	0.5	0.4	0	41.3	52.5	0	124	150	0	28	28
2025	11	15	2	40	0	25.3	-1.5	0.949	0.5	0.4	0	41.7	52.5	0	124	150	0	27	28
2025	11	15	2	50	0	25.4	-2.6	0.949	0.4	0.3	0	41.7	52.5	0	124	150	0	27	28
2025	11	15	3	0	0	25	-2	0.949	0.4	0.3	0	41.3	52.5	0	124	150	0	28	28
2025	11	15	3	10	0	26.8	-1.4	0.949	0.5	0.4	0	41.7	52.5	0	124	150	0	27	28
2025	11	15	3	20	0	26.1	-2.1	0.949	0.4	0.3	0	41.3	52.5	0	124	150	0	28	28
2025	11	15	3	30	0	25.5	-1.2	0.95	0.5	0.5	0	41.7	52.5	0	124	150	0	27	28
2025	11	15	3	40	0	27.1	-1.7	0.95	0.5	0.5	0	41.7	52.9	0	124	150	0	27	27
2025	11	15	3	50	0	26	-1.4	0.95	0.4	0.3	0	41.3	52.5	0	124	150	0	28	28
2025	11	15	4	0	0	25.1	-1.7	0.95	0.5	0.4	0	41.7	52.5	0	124	150	0	27	28
2025	11	15	4	10	0	26.6	-2.8	0.95	0.5	0.4	0	41.7	52.5	0	124	150	0	27	28
2025	11	15	4	20	0	25.5	-2.7	0.95	0.5	0.4	0	41.3	52.5	0	124	150	0	28	28
2025	11	15	4	30	0	25.6	-2.8	0.95	0.5	0.4	0	41.3	52.5	0	124	150	0	28	28
2025	11	15	4	40	0	24.9	-1.9	0.95	0.4	0.3	0	41.3	52.9	0	123	150	0	27	27
2025	11	15	4	50	0	26.5	-1.7	0.951	0.5	0.4	0	41.3	52.5	0	124	150	0	28	28
2025	11	15	5	0	0	25.5	-2.2	0.95	0.5	0.4	0	41.3	52.5	0	124	150	0	28	28
2025	11	15	5	10	0	24.7	-2.4	0.951	0.5	0.4	0	41.7	52.5	0	124	150	0	27	28
2025	11	15	5	20	0	26.9	-2.1	0.951	0.5	0.4	0	40.9	52.5	0	123	150	0	28	28
2025	11	15	5	30	0	25.6	-1.2	0.951	0.5	0.5	0	41.7	52.5	0	124	150	0	27	28
2025	11	15	5	40	0	25.6	-2	0.951	0.4	0.3	0	41.3	52.5	0	124	150	0	28	28
2025	11	15	5	50	0	25.8	-2.5	0.951	0.5	0.5	0	41.3	52.5	0	124	150	0	28	28
2025	11	15	6	0	0	25.2	-2.4	0.951	0.4	0.3	0	41.3	52	0	124	150	0	28	29
2025	11	15	6	10	0	25.8	-2.1	0.952	0.5	0.4	0	41.3	52.5	0	124	150	0	28	28
2025	11	15	6	20	0	26.4	-2.6	0.952	0.5	0.4	0	41.3	52.9	0	124	151	0	28	28
2025	11	15	6	30	0	26	-2.4	0.952	0.5	0.4	0	41.7	52.5	0	124	150	0	27	28
2025	11	15	6	40	0	25.6	-2.6	0.952	0.5	0.4	0	41.7	52.5	0	124	150	0	27	28
2025	11	15	6	50	0	26.1	-2.1	0.952	0.5	0.4	0	41.3	52.9	0	124	150	0	28	27
2025	11	15	7	0	0	25.7	-2.4	0.952	0.3	0.2	0	41.7	52.9	0	124	150	0	27	27
2025	11	15	7	10	0	26.4	-1.7	0.952	0.5	0.4	0	41.7	52.9	0	124	150	0	27	27
2025	11	15	7	20	0	26.8	-1.3	0.953	0.5	0.4	0	41.3	52.5	0	123	150	0	27	28
2025	11	15	7	30	0	25.2	-1.4	0.953	0.5	0.5	0	40.9	52	0	123	149	0	28	28
2025	11	15	7	40	0	27.2	-1.9	0.953	0.5	0.5	0	40.4	52	0	122	149	0	28	28
2025	11	15	7	50	0	25.2	-1.6	0.953	0.5	0.5	0	40.9	52.9	0	123	150	0	28	27

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	15	8	0	0	25.3	-1.7	0.953	0.4	0.3	0	40.9	52.5	0	123	149	0	28	27
2025	11	15	8	10	0	25.6	-1.4	0.953	0.4	0.3	0	40.4	52	0	122	149	0	28	28
2025	11	15	8	20	0	26.2	-2.6	0.953	0.5	0.5	0	40.4	51.6	0	121	148	0	27	28
2025	11	15	8	30	0	25.7	-1.4	0.953	0.5	0.4	0	40	51.6	0	121	148	0	28	28
2025	11	15	8	40	0	24.7	-1.3	0.954	0.5	0.4	0	40.4	51.6	0	121	148	0	27	28
2025	11	15	8	50	0	26.6	-1.5	0.954	0.4	0.3	0	39.6	51.2	0	120	146	0	28	27
2025	11	15	9	0	0	25.3	-2.3	0.954	0.4	0.3	0	39.1	50.7	0	119	146	0	28	28
2025	11	15	9	10	0	25	-1.7	0.954	0.4	0.3	0	40	50.7	0	120	146	0	27	28
2025	11	15	9	20	0	26.3	-2	0.954	0.5	0.5	0	40	51.6	0	121	148	0	28	28
2025	11	15	9	30	0	26.9	-1.8	0.954	0.5	0.4	0	39.6	51.2	0	120	147	0	28	28
2025	11	15	9	40	0	25.8	-1.8	0.954	0.5	0.4	0	40	51.2	0	120	147	0	27	28
2025	11	15	9	50	0	26.1	-1.3	0.954	0.3	0.2	0	40	50.7	0	120	146	0	27	28
2025	11	15	10	0	0	25	-1.3	0.955	0.5	0.4	0	39.6	50.7	0	119	146	0	27	28
2025	11	15	10	10	0	26.5	-2.2	0.955	0.5	0.4	0	39.6	50.7	0	119	146	0	27	28
2025	11	15	10	20	0	26.4	-2.1	0.955	0.5	0.4	0	38.7	49.9	0	117	144	0	27	28
2025	11	15	10	30	0	25.3	-1.7	0.955	0.5	0.4	0	38.7	49.5	0	117	143	0	27	28
2025	11	15	10	40	0	26.5	-1.7	0.955	0.5	0.5	0	38.3	49.9	0	116	143	0	27	27
2025	11	15	10	50	0	26.1	-0.3	0.955	0.5	0.5	0	37.8	49	0	116	142	0	28	28
2025	11	15	11	0	0	26.1	-1.3	0.956	0.3	0.2	0	37.8	49	0	116	142	0	28	28
2025	11	15	11	10	0	26.9	-0.9	0.956	0.6	0.5	0	37.4	48.6	0	115	141	0	28	28
2025	11	15	11	20	0	27.1	-2.8	0.956	0.4	0.3	0	37.4	48.6	0	115	141	0	28	28
2025	11	15	11	30	0	25.6	-1.9	0.956	0.5	0.4	0	37	48.6	0	114	141	0	28	28
2025	11	15	11	40	0	26.9	-1.3	0.956	0.5	0.4	0	37.4	49	0	114	141	0	27	27
2025	11	15	11	50	0	25.8	-2	0.956	0.5	0.4	0	37.4	48.2	0	114	140	0	27	28
2025	11	15	12	0	0	26.1	-3.2	0.956	0.5	0.4	0	37.4	48.6	0	114	141	0	27	28
2025	11	15	12	10	0	26.3	-1.3	0.957	0.5	0.5	0	37	48.2	0	113	140	0	27	28
2025	11	15	12	20	0	27.3	-2.1	0.957	0.4	0.3	0	37.4	48.2	0	114	140	0	27	28
2025	11	15	12	30	0	25.8	-1.7	0.957	0.4	0.3	0	37.4	48.2	0	114	140	0	27	28
2025	11	15	12	40	0	26.9	-2.1	0.957	0.4	0.3	0	37	48.2	0	113	140	0	27	28
2025	11	15	12	50	0	25.8	-2.1	0.957	0.4	0.3	0	36.5	48.2	0	113	140	0	28	28
2025	11	15	13	0	0	26.7	-3	0.957	0.5	0.4	0	37	47.7	0	113	139	0	27	28
2025	11	15	13	10	0	25.8	-1.6	0.957	0.5	0.4	0	37	48.2	0	113	140	0	27	28
2025	11	15	13	20	0	25.9	-2.4	0.958	0.5	0.4	0	37	48.2	0	113	140	0	27	28
2025	11	15	13	30	0	26.1	-1.8	0.958	0.5	0.4	0	37	48.6	0	113	140	0	27	27
2025	11	15	13	40	0	26.9	-2.2	0.958	0.5	0.4	0	36.5	48.2	0	113	140	0	28	28
2025	11	15	13	50	0	26	-2.1	0.959	0.4	0.3	0	36.5	48.2	0	113	140	0	28	28
2025	11	15	14	0	0	27.4	-2.4	0.959	0.6	0.5	0	37	47.7	0	113	139	0	27	28
2025	11	15	14	10	0	26.5	-2	0.96	0.4	0.3	0	37	48.2	0	113	140	0	27	28
2025	11	15	14	20	0	26.2	-2.1	0.959	0.4	0.3	0	37.4	48.2	0	114	140	0	27	28
2025	11	15	14	30	0	24.9	-2.2	0.961	0.5	0.4	0	37	48.2	0	113	140	0	27	28
2025	11	15	14	40	0	25.9	-2.2	0.961	0.4	0.3	0	37	49	0	114	141	0	28	27
2025	11	15	14	50	0	26.8	-1.8	0.961	0.5	0.4	0	37.4	49.5	0	115	142	0	28	27
2025	11	15	15	0	0	27.1	-2.5	0.961	0.5	0.4	0	37.8	49.5	0	115	142	0	27	27
2025	11	15	15	10	0	25.7	-2	0.961	0.5	0.4	0	37.8	49	0	115	142	0	27	28
2025	11	15	15	20	0	25.7	-1.3	0.962	0.5	0.5	0	38.3	49.5	0	116	143	0	27	28
2025	11	15	15	30	0	27	-1.8	0.963	0.5	0.4	0	38.3	49.5	0	116	143	0	27	28
2025	11	15	15	40	0	26.2	-1.7	0.963	0.5	0.4	0	38.3	49.5	0	116	143	0	27	28
2025	11	15	15	50	0	27.8	-3	0.963	0.4	0.3	0	37.8	49.5	0	116	143	0	28	28

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	15	16	0	0	25.6	-2.2	0.964	0.4	0.3	0	38.3	49.5	0	116	143	0	27	28
2025	11	15	16	10	0	25.8	-1.3	0.965	0.4	0.3	0	38.3	49.5	0	116	143	0	27	28
2025	11	15	16	20	0	26.4	-1.7	0.965	0.4	0.3	0	38.3	49.5	0	116	143	0	27	28
2025	11	15	16	30	0	26.4	-1.9	0.965	0.4	0.3	0	38.7	49.9	0	117	144	0	27	28
2025	11	15	16	40	0	26.4	-1.6	0.965	0.5	0.4	0	38.3	49.9	0	116	143	0	27	27
2025	11	15	16	50	0	25.8	-1.3	0.966	0.5	0.4	0	38.3	50.3	0	117	144	0	28	27
2025	11	15	17	0	0	26.2	-1.2	0.966	0.4	0.3	0	37.4	49.5	0	115	143	0	28	28
2025	11	15	17	10	0	27.2	-2.2	0.966	0.5	0.4	0	37.8	49	0	115	142	0	27	28
2025	11	15	17	20	0	26.6	-1.7	0.966	0.5	0.4	0	37.4	49.5	0	115	142	0	28	27
2025	11	15	17	30	0	26	-3	0.966	0.5	0.4	0	37.4	49.5	0	115	142	0	28	27
2025	11	15	17	40	0	26.4	-2.2	0.966	0.5	0.4	0	37.4	49.5	0	115	143	0	28	28
2025	11	15	17	50	0	27.4	-2.2	0.966	0.4	0.3	0	37.8	49.5	0	116	143	0	28	28
2025	11	15	18	0	0	26.1	-1.8	0.967	0.5	0.4	0	38.7	49.9	0	117	144	0	27	28
2025	11	15	18	10	0	26.7	-1.4	0.967	0.6	0.5	0	38.7	50.3	0	117	144	0	27	27
2025	11	15	18	20	0	26.8	-1.8	0.968	0.5	0.5	0	39.1	50.7	0	119	146	0	28	28
2025	11	15	18	30	0	26.9	-1.3	0.968	0.4	0.3	0	39.6	51.2	0	119	146	0	27	27
2025	11	15	18	40	0	27.1	-2	0.968	0.5	0.5	0	39.1	50.3	0	118	145	0	27	28
2025	11	15	18	50	0	26.8	-1.7	0.968	0.5	0.5	0	39.1	50.3	0	118	145	0	27	28
2025	11	15	19	0	0	26.1	-2.5	0.968	0.4	0.3	0	38.3	50.3	0	117	144	0	28	27
2025	11	15	19	10	0	26.8	-2	0.968	0.5	0.5	0	38.7	50.7	0	118	145	0	28	27
2025	11	15	19	20	0	25.8	-2.1	0.968	0.3	0.2	0	39.1	50.3	0	118	145	0	27	28
2025	11	15	19	30	0	27.6	-2	0.968	0.5	0.4	0	38.7	50.3	0	118	145	0	28	28
2025	11	15	19	40	0	27	-1.6	0.968	0.5	0.4	0	39.1	50.7	0	118	145	0	27	27
2025	11	15	19	50	0	26.4	-1.7	0.968	0.3	0.2	0	38.7	50.7	0	118	146	0	28	28
2025	11	15	20	0	0	26.2	-1.1	0.968	0.5	0.4	0	39.1	50.7	0	119	146	0	28	28
2025	11	15	20	10	0	26.7	-2.4	0.968	0.4	0.3	0	39.6	50.7	0	119	146	0	27	28
2025	11	15	20	20	0	25.8	-2.1	0.969	0.4	0.3	0	39.1	51.2	0	119	146	0	28	27
2025	11	15	20	30	0	26.4	-1.6	0.969	0.5	0.5	0	39.1	51.2	0	119	146	0	28	27
2025	11	15	20	40	0	25.7	-2.1	0.969	0.3	0.2	0	39.6	51.2	0	119	147	0	27	28
2025	11	15	20	50	0	27.1	-0.5	0.969	0.5	0.4	0	39.6	51.2	0	120	147	0	28	28
2025	11	15	21	0	0	26.8	-1.7	0.969	0.4	0.3	0	39.6	51.2	0	120	146	0	28	27
2025	11	15	21	10	0	27.5	-1.7	0.969	0.6	0.5	0	39.6	51.2	0	119	147	0	27	28
2025	11	15	21	20	0	27.6	-2.3	0.968	0.5	0.4	0	39.1	50.7	0	119	146	0	28	28
2025	11	15	21	30	0	26.1	-1.3	0.968	0.4	0.3	0	39.6	50.7	0	119	147	0	27	29
2025	11	15	21	40	0	26.6	-2.5	0.968	0.5	0.4	0	39.6	50.7	0	119	146	0	27	28
2025	11	15	21	50	0	27.2	-1.9	0.968	0.3	0.2	0	39.6	51.2	0	119	147	0	27	28
2025	11	15	22	0	0	27	-1.9	0.968	0.4	0.3	0	40	51.2	0	119	147	0	26	28
2025	11	15	22	10	0	27	-1.6	0.968	0.5	0.4	0	39.6	51.2	0	120	147	0	28	28
2025	11	15	22	20	0	26.9	-3	0.969	0.4	0.3	0	39.6	51.2	0	120	147	0	28	28
2025	11	15	22	30	0	27.2	-2.6	0.969	0.4	0.3	0	39.6	51.2	0	120	147	0	28	28
2025	11	15	22	40	0	26.6	-1.3	0.97	0.4	0.3	0	39.6	51.2	0	120	147	0	28	28
2025	11	15	22	50	0	26.2	-0.9	0.97	0.5	0.4	0	40	51.6	0	121	148	0	28	28
2025	11	15	23	0	0	26.7	-2.9	0.97	0.5	0.4	0	39.6	51.6	0	120	147	0	28	27
2025	11	15	23	10	0	27.1	-1.2	0.97	0.4	0.3	0	39.6	51.2	0	120	147	0	28	28
2025	11	15	23	20	0	25.8	-2.1	0.97	0.3	0.2	0	40	51.2	0	120	147	0	27	28
2025	11	15	23	30	0	26.9	-1.7	0.97	0.4	0.3	0	39.6	51.2	0	119	147	0	27	28
2025	11	15	23	40	0	28.1	-2.6	0.969	0.5	0.4	0	39.6	50.7	0	119	146	0	27	28
2025	11	15	23	50	0	26.4	-0.9	0.968	0.5	0.4	0	39.6	51.2	0	120	147	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	16	0	0	0	26.5	-1.7	0.968	0.4	0.3	0	39.6	51.2	0	119	147	0	27	28
2025	11	16	0	10	0	26.9	-3	0.968	0.5	0.4	0	39.6	51.2	0	119	147	0	27	28
2025	11	16	0	20	0	27.3	-2.4	0.969	0.5	0.5	0	39.6	50.7	0	119	146	0	27	28
2025	11	16	0	30	0	27.3	-2.2	0.969	0.5	0.4	0	39.1	51.2	0	119	146	0	28	27
2025	11	16	0	40	0	27.3	-2.3	0.968	0.5	0.4	0	39.1	51.6	0	119	147	0	28	27
2025	11	16	0	50	0	27.3	-2.4	0.968	0.5	0.5	0	39.6	51.2	0	119	147	0	27	28
2025	11	16	1	0	0	25.9	-2.3	0.968	0.5	0.4	0	39.1	50.7	0	119	146	0	28	28
2025	11	16	1	10	0	26.8	-2.1	0.967	0.5	0.5	0	39.1	50.3	0	119	146	0	28	29
2025	11	16	1	20	0	27.8	-2.2	0.968	0.5	0.4	0	39.6	51.2	0	119	147	0	27	28
2025	11	16	1	30	0	27.4	-2	0.968	0.5	0.4	0	39.6	50.7	0	119	146	0	27	28
2025	11	16	1	40	0	27.6	-1.8	0.967	0.5	0.4	0	39.1	51.2	0	119	146	0	28	27
2025	11	16	1	50	0	25.7	-2.1	0.967	0.5	0.5	0	39.1	50.7	0	119	147	0	28	29
2025	11	16	2	0	0	27.7	-2.1	0.967	0.5	0.4	0	39.6	51.2	0	119	147	0	27	28
2025	11	16	2	10	0	27	-1.9	0.967	0.5	0.4	0	39.1	50.7	0	119	146	0	28	28
2025	11	16	2	20	0	27.6	-1.2	0.967	0.5	0.4	0	39.6	50.7	0	119	146	0	27	28
2025	11	16	2	30	0	26.6	-1.8	0.967	0.5	0.5	0	39.1	51.2	0	119	147	0	28	28
2025	11	16	2	40	0	28.1	-2.3	0.966	0.5	0.4	0	39.1	50.7	0	118	146	0	27	28
2025	11	16	2	50	0	27.6	-2.1	0.966	0.5	0.4	0	39.6	50.7	0	119	146	0	27	28
2025	11	16	3	0	0	26.8	-2.4	0.966	0.5	0.4	0	39.6	50.7	0	119	146	0	27	28
2025	11	16	3	10	0	27.4	-1.8	0.966	0.4	0.3	0	39.6	50.7	0	119	146	0	27	28
2025	11	16	3	20	0	25.6	-2.2	0.966	0.4	0.3	0	39.1	50.7	0	118	146	0	27	28
2025	11	16	3	30	0	27	-3	0.966	0.5	0.4	0	39.1	51.2	0	118	146	0	27	27
2025	11	16	3	40	0	27.2	-2.4	0.966	0.5	0.4	0	39.6	51.2	0	119	147	0	27	28
2025	11	16	3	50	0	27.1	-1.5	0.965	0.5	0.4	0	38.7	50.7	0	118	146	0	28	28
2025	11	16	4	0	0	27	-2.7	0.965	0.4	0.3	0	39.1	50.7	0	119	146	0	28	28
2025	11	16	4	10	0	26.8	-2.3	0.965	0.4	0.3	0	39.6	50.7	0	119	147	0	27	29
2025	11	16	4	20	0	27.1	-2.1	0.965	0.5	0.4	0	39.1	50.7	0	119	146	0	28	28
2025	11	16	4	30	0	26.1	-2.3	0.965	0.5	0.5	0	39.1	51.2	0	119	147	0	28	28
2025	11	16	4	40	0	27.2	-1.7	0.965	0.4	0.3	0	39.1	51.2	0	119	147	0	28	28
2025	11	16	4	50	0	26.4	-1.8	0.965	0.4	0.3	0	39.6	50.7	0	119	146	0	27	28
2025	11	16	5	0	0	26.3	-2.6	0.965	0.5	0.4	0	39.6	51.2	0	119	147	0	27	28
2025	11	16	5	10	0	25.8	-2.4	0.965	0.4	0.3	0	39.6	51.2	0	119	147	0	27	28
2025	11	16	5	20	0	26.3	-2.5	0.964	0.5	0.5	0	39.6	51.2	0	119	147	0	27	28
2025	11	16	5	30	0	26	-2.2	0.965	0.4	0.3	0	39.6	51.2	0	119	147	0	27	28
2025	11	16	5	40	0	26.2	-2.7	0.965	0.4	0.3	0	38.7	51.6	0	119	147	0	29	27
2025	11	16	5	50	0	27.2	-1.9	0.964	0.4	0.3	0	39.1	51.2	0	119	147	0	28	28
2025	11	16	6	0	0	26.2	-2.1	0.964	0.5	0.4	0	39.6	51.2	0	119	147	0	27	28
2025	11	16	6	10	0	26.6	-1.5	0.964	0.5	0.4	0	39.1	51.2	0	119	147	0	28	28
2025	11	16	6	20	0	27.1	-1.7	0.964	0.5	0.4	0	39.1	51.2	0	119	147	0	28	28
2025	11	16	6	30	0	26.3	-2	0.964	0.4	0.3	0	39.1	51.2	0	119	147	0	28	28
2025	11	16	6	40	0	26.6	-2.6	0.964	0.5	0.4	0	39.1	51.2	0	119	147	0	28	28
2025	11	16	6	50	0	27	-1.7	0.964	0.5	0.5	0	39.1	51.2	0	119	147	0	28	28
2025	11	16	7	0	0	27	-1.3	0.964	0.5	0.5	0	39.6	51.2	0	119	147	0	27	28
2025	11	16	7	10	0	26.5	-1.7	0.964	0.5	0.4	0	38.7	50.7	0	118	146	0	28	28
2025	11	16	7	20	0	27.4	-2	0.964	0.5	0.5	0	38.7	51.6	0	118	147	0	28	27
2025	11	16	7	30	0	26.4	-1.8	0.964	0.4	0.3	0	38.7	50.7	0	118	146	0	28	28
2025	11	16	7	40	0	26.8	-2.2	0.964	0.4	0.3	0	39.1	50.7	0	118	146	0	27	28
2025	11	16	7	50	0	26.6	-2.1	0.964	0.4	0.3	0	38.7	50.3	0	117	145	0	27	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	16	8	0	0	26	-2.2	0.964	0.5	0.4	0	38.3	50.3	0	117	145	0	28	28
2025	11	16	8	10	0	26.8	-2.5	0.964	0.5	0.4	0	37.8	49.5	0	116	144	0	28	29
2025	11	16	8	20	0	27	-2.4	0.964	0.5	0.4	0	37.4	49.5	0	115	143	0	28	28
2025	11	16	8	30	0	26.2	-2.1	0.964	0.5	0.4	0	37.8	49.5	0	115	143	0	27	28
2025	11	16	8	40	0	27.7	-3.1	0.964	0.4	0.3	0	37.8	49	0	115	142	0	27	28
2025	11	16	8	50	0	27.1	-3.3	0.964	0.6	0.5	0	37	49.5	0	114	143	0	28	28
2025	11	16	9	0	0	26.2	-2.5	0.964	0.5	0.4	0	37.4	49	0	114	142	0	27	28
2025	11	16	9	10	0	26.8	-2.9	0.965	0.5	0.4	0	37	48.6	0	113	141	0	27	28
2025	11	16	9	20	0	25.6	-2	0.964	0.5	0.4	0	36.1	48.2	0	112	140	0	28	28
2025	11	16	9	30	0	26.2	-2.8	0.964	0.5	0.4	0	36.1	48.2	0	112	140	0	28	28
2025	11	16	9	40	0	26.5	-2.1	0.964	0.5	0.4	0	36.5	48.2	0	112	140	0	27	28
2025	11	16	9	50	0	26.6	-2.2	0.964	0.5	0.4	0	36.1	47.7	0	112	139	0	28	28
2025	11	16	10	0	0	26.8	-2.2	0.964	0.4	0.3	0	35.7	48.2	0	111	139	0	28	27
2025	11	16	10	10	0	27.6	-3.2	0.964	0.3	0.2	0	35.3	47.3	0	110	138	0	28	28
2025	11	16	10	20	0	26.1	-2.7	0.965	0.5	0.4	0	36.1	47.3	0	111	138	0	27	28
2025	11	16	10	30	0	26.6	-2.4	0.965	0.5	0.4	0	35.3	47.3	0	110	138	0	28	28
2025	11	16	10	40	0	26.7	-2.6	0.965	0.4	0.3	0	35.7	46.9	0	110	137	0	27	28
2025	11	16	10	50	0	25.4	-2.3	0.965	0.5	0.4	0	35.3	46.9	0	110	137	0	28	28
2025	11	16	11	0	0	25.6	-2	0.965	0.4	0.3	0	34.8	46.9	0	109	137	0	28	28
2025	11	16	11	10	0	26.7	-1.8	0.965	0.5	0.5	0	34.8	46.9	0	109	137	0	28	28
2025	11	16	11	20	0	26.9	-2.6	0.965	0.5	0.4	0	35.3	46.4	0	109	136	0	27	28
2025	11	16	11	30	0	26.6	-1.7	0.965	0.3	0.2	0	35.3	46.9	0	109	137	0	27	28
2025	11	16	11	40	0	26.3	-2.7	0.965	0.5	0.5	0	35.3	46.9	0	110	137	0	28	28
2025	11	16	11	50	0	26.2	-2.8	0.965	0.4	0.3	0	34.8	47.3	0	109	137	0	28	27
2025	11	16	12	0	0	26.3	-2.4	0.965	0.5	0.4	0	34.8	46.9	0	109	137	0	28	28
2025	11	16	12	10	0	26.7	-2.6	0.965	0.5	0.4	0	35.3	46.9	0	109	137	0	27	28
2025	11	16	12	20	0	26.6	-1.9	0.966	0.5	0.4	0	35.3	46.9	0	110	137	0	28	28
2025	11	16	12	30	0	26.3	-3.9	0.966	0.4	0.3	0	35.3	46.4	0	109	137	0	27	29
2025	11	16	12	40	0	25.8	-2.5	0.966	0.3	0.2	0	35.3	46.4	0	109	136	0	27	28
2025	11	16	12	50	0	25.7	-2.8	0.967	0.5	0.4	0	34.4	46.4	0	108	136	0	28	28
2025	11	16	13	0	0	26	-2.5	0.967	0.5	0.5	0	34.8	46.4	0	108	136	0	27	28
2025	11	16	13	10	0	26.6	-3	0.967	0.4	0.3	0	34.8	46.9	0	109	137	0	28	28
2025	11	16	13	20	0	26.2	-3	0.968	0.4	0.3	0	36.5	48.2	0	113	140	0	28	28
2025	11	16	13	30	0	26.7	-2.2	0.967	0.4	0.3	0	36.5	48.2	0	113	140	0	28	28
2025	11	16	13	40	0	27	-3.4	0.967	0.5	0.4	0	36.1	48.2	0	112	140	0	28	28
2025	11	16	13	50	0	26.2	-2.4	0.968	0.4	0.3	0	35.7	48.2	0	112	140	0	29	28
2025	11	16	14	0	0	27.2	-2	0.967	0.5	0.4	0	35.7	47.3	0	111	139	0	28	29
2025	11	16	14	10	0	26.7	-2.4	0.968	0.3	0.2	0	37	48.2	0	113	140	0	27	28
2025	11	16	14	20	0	26.5	-2.4	0.969	0.3	0.2	0	37.4	49	0	115	142	0	28	28
2025	11	16	14	30	0	27.5	-2	0.969	0.4	0.3	0	36.1	48.2	0	112	140	0	28	28
2025	11	16	14	40	0	25.8	-2.2	0.97	0.5	0.4	0	36.1	48.2	0	111	139	0	27	27
2025	11	16	14	50	0	26.4	-2.8	0.97	0.4	0.3	0	35.7	47.7	0	111	139	0	28	28
2025	11	16	15	0	0	27.1	-2.9	0.97	0.5	0.4	0	35.7	47.3	0	111	138	0	28	28
2025	11	16	15	10	0	27.1	-1.9	0.97	0.4	0.3	0	36.1	47.7	0	112	139	0	28	28
2025	11	16	15	20	0	26.1	-2.5	0.971	0.4	0.3	0	36.5	48.2	0	113	140	0	28	28
2025	11	16	15	30	0	26.6	-2.5	0.971	0.5	0.5	0	37	48.6	0	113	141	0	27	28
2025	11	16	15	40	0	27.6	-2.7	0.971	0.5	0.4	0	37	48.2	0	113	140	0	27	28
2025	11	16	15	50	0	26.1	-3.4	0.972	0.5	0.5	0	36.1	48.2	0	112	140	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	16	16	0	0	26.9	-2	0.972	0.5	0.4	0	36.1	48.2	0	112	140	0	28	28
2025	11	16	16	10	0	26.5	-2.9	0.972	0.5	0.4	0	36.5	48.2	0	113	140	0	28	28
2025	11	16	16	20	0	26.1	-2.5	0.972	0.5	0.4	0	36.5	48.6	0	113	141	0	28	28
2025	11	16	16	30	0	26.7	-2	0.973	0.4	0.3	0	36.5	48.6	0	113	141	0	28	28
2025	11	16	16	40	0	27.6	-2.3	0.974	0.5	0.4	0	36.5	48.6	0	113	141	0	28	28
2025	11	16	16	50	0	27.2	-2.2	0.974	0.4	0.3	0	36.5	48.2	0	112	140	0	27	28
2025	11	16	17	0	0	28	-2.4	0.974	0.4	0.3	0	36.1	48.6	0	112	141	0	28	28
2025	11	16	17	10	0	26.7	-1.3	0.974	0.5	0.4	0	36.5	48.6	0	113	141	0	28	28
2025	11	16	17	20	0	27	-2.1	0.975	0.4	0.3	0	37	48.6	0	113	141	0	27	28
2025	11	16	17	30	0	27.1	-2	0.975	0.5	0.4	0	36.5	49	0	113	141	0	28	27
2025	11	16	17	40	0	26.7	-1.8	0.975	0.4	0.3	0	37	48.6	0	113	141	0	27	28
2025	11	16	17	50	0	26.3	-1.8	0.975	0.5	0.4	0	37	48.6	0	113	141	0	27	28
2025	11	16	18	0	0	27.4	-2.1	0.975	0.5	0.4	0	36.5	49	0	113	142	0	28	28
2025	11	16	18	10	0	27	-1.7	0.976	0.5	0.5	0	37	49.5	0	114	142	0	28	27
2025	11	16	18	20	0	28.2	-1.8	0.975	0.5	0.4	0	37.4	49	0	114	142	0	27	28
2025	11	16	18	30	0	26.5	-2.1	0.976	0.5	0.4	0	37	49.5	0	114	143	0	28	28
2025	11	16	18	40	0	26.5	-2.4	0.976	0.4	0.3	0	37.4	49.5	0	115	143	0	28	28
2025	11	16	18	50	0	27.3	-1.1	0.976	0.5	0.4	0	37	49.5	0	114	143	0	28	28
2025	11	16	19	0	0	26.6	-1	0.976	0.5	0.4	0	37.4	49.9	0	115	144	0	28	28
2025	11	16	19	10	0	27.6	-1.9	0.976	0.5	0.5	0	37.8	49.9	0	115	144	0	27	28
2025	11	16	19	20	0	27.5	-1.7	0.977	0.4	0.3	0	38.3	49.9	0	116	144	0	27	28
2025	11	16	19	30	0	27.9	-2.5	0.977	0.5	0.5	0	37.8	49.9	0	115	144	0	27	28
2025	11	16	19	40	0	26.5	-1.6	0.977	0.4	0.3	0	37.8	50.3	0	116	145	0	28	28
2025	11	16	19	50	0	27.7	-1.5	0.977	0.4	0.3	0	37.4	49.9	0	115	144	0	28	28
2025	11	16	20	0	0	27.8	-2.1	0.977	0.5	0.4	0	37.8	49.5	0	116	144	0	28	29
2025	11	16	20	10	0	26.7	-0.9	0.977	0.5	0.4	0	37.8	50.3	0	116	145	0	28	28
2025	11	16	20	20	0	27.9	-2.1	0.978	0.5	0.4	0	37.8	50.7	0	116	145	0	28	27
2025	11	16	20	30	0	28.7	-2.1	0.978	0.5	0.4	0	38.3	49.9	0	116	144	0	27	28
2025	11	16	20	40	0	27.5	-1.1	0.978	0.4	0.3	0	37.4	50.3	0	116	145	0	29	28
2025	11	16	20	50	0	27.8	-2.5	0.978	0.5	0.4	0	37.8	50.3	0	116	145	0	28	28
2025	11	16	21	0	0	26.8	-3.4	0.978	0.5	0.4	0	37.8	50.3	0	116	145	0	28	28
2025	11	16	21	10	0	28.3	-2.5	0.98	0.4	0.3	0	37.8	50.3	0	116	145	0	28	28
2025	11	16	21	20	0	28.2	-2.3	0.98	0.5	0.4	0	37.8	50.3	0	116	145	0	28	28
2025	11	16	21	30	0	27.4	-1.3	0.981	0.4	0.3	0	38.3	50.3	0	117	145	0	28	28
2025	11	16	21	40	0	27.7	-1.8	0.981	0.5	0.4	0	38.3	50.3	0	116	145	0	27	28
2025	11	16	21	50	0	27.8	-1.7	0.982	0.4	0.3	0	37.8	50.3	0	116	145	0	28	28
2025	11	16	22	0	0	27.4	-1.1	0.982	0.4	0.3	0	37.8	50.7	0	116	146	0	28	28
2025	11	16	22	10	0	26.6	-1.7	0.982	0.4	0.3	0	37.4	50.3	0	115	145	0	28	28
2025	11	16	22	20	0	27.3	-0.8	0.982	0.4	0.3	0	37.8	49.9	0	116	145	0	28	29
2025	11	16	22	30	0	28.1	-2.4	0.983	0.5	0.5	0	38.3	50.3	0	116	145	0	27	28
2025	11	16	22	40	0	27.7	-1.3	0.983	0.5	0.4	0	37.4	50.3	0	116	145	0	29	28
2025	11	16	22	50	0	28.6	-1.4	0.983	0.5	0.4	0	38.3	50.3	0	116	145	0	27	28
2025	11	16	23	0	0	27.3	-1.3	0.983	0.5	0.4	0	38.3	50.3	0	116	145	0	27	28
2025	11	16	23	10	0	27.4	-2.1	0.983	0.5	0.4	0	37.8	50.3	0	116	145	0	28	28
2025	11	16	23	20	0	28.3	-2.9	0.983	0.4	0.3	0	38.3	50.3	0	116	145	0	27	28
2025	11	16	23	30	0	28.2	-1.7	0.983	0.4	0.3	0	38.3	50.3	0	116	145	0	27	28
2025	11	16	23	40	0	28	-1.3	0.983	0.3	0.2	0	37.8	49.9	0	116	145	0	28	29
2025	11	16	23	50	0	28.1	-1.9	0.983	0.5	0.5	0	37.8	50.3	0	116	145	0	28	28

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	17	0	0	0	27.4	-1.4	0.983	0.3	0.2	0	37.8	50.3	0	116	145	0	28	28
2025	11	17	0	10	0	27.6	-1.8	0.983	0.5	0.4	0	37.8	49.9	0	116	145	0	28	29
2025	11	17	0	20	0	27.5	-2.5	0.983	0.5	0.5	0	38.3	50.3	0	116	145	0	27	28
2025	11	17	0	30	0	27.2	-2.1	0.983	0.4	0.3	0	38.3	50.3	0	116	145	0	27	28
2025	11	17	0	40	0	28.5	-1.5	0.983	0.4	0.3	0	38.3	50.3	0	117	146	0	28	29
2025	11	17	0	50	0	27.5	-2	0.983	0.4	0.3	0	37.8	50.3	0	116	145	0	28	28
2025	11	17	1	0	0	28.5	-1.1	0.983	0.4	0.3	0	38.7	50.7	0	117	146	0	27	28
2025	11	17	1	10	0	27.5	-2.1	0.983	0.3	0.2	0	37.8	50.3	0	116	145	0	28	28
2025	11	17	1	20	0	27.7	-1.4	0.983	0.4	0.3	0	38.7	50.7	0	117	146	0	27	28
2025	11	17	1	30	0	27.4	-2.2	0.983	0.5	0.4	0	37.8	50.3	0	116	145	0	28	28
2025	11	17	1	40	0	27	-1.7	0.983	0.5	0.4	0	37.8	50.3	0	116	146	0	28	29
2025	11	17	1	50	0	27.6	-1.8	0.983	0.5	0.5	0	38.7	50.3	0	117	146	0	27	29
2025	11	17	2	0	0	27.8	-2.1	0.983	0.3	0.2	0	38.7	50.7	0	117	146	0	27	28
2025	11	17	2	10	0	27.8	-2.1	0.983	0.4	0.3	0	37.8	50.7	0	116	146	0	28	28
2025	11	17	2	20	0	28.1	-2.1	0.983	0.5	0.5	0	38.7	50.3	0	117	146	0	27	29
2025	11	17	2	30	0	27.1	-1.4	0.983	0.4	0.3	0	38.3	50.7	0	117	146	0	28	28
2025	11	17	2	40	0	26.2	-1.7	0.983	0.5	0.5	0	38.7	51.2	0	117	147	0	27	28
2025	11	17	2	50	0	27.4	-1.9	0.983	0.5	0.5	0	38.7	50.7	0	118	147	0	28	29
2025	11	17	3	0	0	27.1	-2.1	0.983	0.4	0.3	0	39.1	51.6	0	119	148	0	28	28
2025	11	17	3	10	0	27.4	-2	0.983	0.5	0.5	0	39.1	51.6	0	119	148	0	28	28
2025	11	17	3	20	0	27.9	-1.4	0.983	0.5	0.5	0	39.6	52	0	120	150	0	28	29
2025	11	17	3	30	0	26.7	-1.9	0.983	0.5	0.5	0	40	52.9	0	121	150	0	28	27
2025	11	17	3	40	0	26.5	-1.2	0.983	0.4	0.3	0	40.4	52.9	0	122	151	0	28	28
2025	11	17	3	50	0	26.8	-1.3	0.982	0.5	0.4	0	41.3	53.3	0	123	152	0	27	28
2025	11	17	4	0	0	26.9	-1.6	0.982	0.5	0.4	0	40.9	53.8	0	123	153	0	28	28
2025	11	17	4	10	0	27.1	-1.7	0.982	0.4	0.3	0	41.3	53.8	0	124	153	0	28	28
2025	11	17	4	20	0	26.6	-2.1	0.982	0.4	0.3	0	41.3	53.8	0	124	154	0	28	29
2025	11	17	4	30	0	27.8	-0.9	0.982	0.5	0.5	0	41.7	53.8	0	125	154	0	28	29
2025	11	17	4	40	0	28.2	-1.7	0.982	0.4	0.3	0	41.3	54.2	0	124	154	0	28	28
2025	11	17	4	50	0	27.3	-2.1	0.982	0.4	0.3	0	41.7	54.2	0	125	154	0	28	28
2025	11	17	5	0	0	27.4	-1.8	0.982	0.5	0.4	0	41.7	53.8	0	125	154	0	28	29
2025	11	17	5	10	0	27.1	-1.3	0.981	0.5	0.4	0	41.7	54.2	0	125	155	0	28	29
2025	11	17	5	20	0	27.3	-2.7	0.981	0.5	0.4	0	41.7	54.6	0	125	155	0	28	28
2025	11	17	5	30	0	27.3	-0.5	0.981	0.4	0.3	0	41.7	54.6	0	125	155	0	28	28
2025	11	17	5	40	0	26.9	-0.8	0.981	0.4	0.3	0	41.7	54.6	0	125	155	0	28	28
2025	11	17	5	50	0	27	-2.1	0.981	0.4	0.3	0	42.1	54.6	0	126	155	0	28	28
2025	11	17	6	0	0	26.6	-0.4	0.98	0.5	0.4	0	42.1	54.6	0	126	155	0	28	28
2025	11	17	6	10	0	26.5	-1.7	0.98	0.4	0.3	0	42.6	54.2	0	126	155	0	27	29
2025	11	17	6	20	0	26.8	-1.3	0.98	0.4	0.3	0	41.7	54.2	0	125	155	0	28	29
2025	11	17	6	30	0	27.3	-1.6	0.98	0.5	0.5	0	41.3	54.6	0	125	155	0	29	28
2025	11	17	6	40	0	27	-1.6	0.98	0.5	0.4	0	41.7	54.6	0	125	155	0	28	28
2025	11	17	6	50	0	26.8	-1.5	0.98	0.3	0.2	0	41.7	54.2	0	125	154	0	28	28
2025	11	17	7	0	0	26.4	-2.5	0.979	0.3	0.2	0	41.7	53.8	0	125	154	0	28	29
2025	11	17	7	10	0	26.9	-2.1	0.979	0.4	0.3	0	41.7	53.8	0	125	154	0	28	29
2025	11	17	7	20	0	26.8	-1.6	0.979	0.4	0.3	0	41.3	54.2	0	124	154	0	28	28
2025	11	17	7	30	0	27	-1.2	0.978	0.4	0.3	0	41.7	54.2	0	125	154	0	28	28
2025	11	17	7	40	0	27.2	-1.1	0.978	0.5	0.4	0	41.3	54.2	0	124	154	0	28	28
2025	11	17	7	50	0	26.3	-1.5	0.978	0.5	0.4	0	41.3	54.2	0	124	154	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	17	8	0	0	26.7	-2.4	0.978	0.5	0.4	0	41.3	53.8	0	124	153	0	28	28
2025	11	17	8	10	0	27.2	-1.2	0.977	0.5	0.5	0	41.3	53.3	0	124	153	0	28	29
2025	11	17	8	20	0	26.3	-2.5	0.976	0.5	0.4	0	41.3	53.8	0	124	153	0	28	28
2025	11	17	8	30	0	26.7	-1.2	0.976	0.5	0.5	0	41.3	54.2	0	124	154	0	28	28
2025	11	17	8	40	0	27.2	-1.5	0.975	0.4	0.3	0	41.7	53.8	0	125	154	0	28	29
2025	11	17	8	50	0	27.2	-2	0.974	0.4	0.3	0	41.3	53.8	0	124	153	0	28	28
2025	11	17	9	0	0	26.8	-0.5	0.973	0.4	0.3	0	41.3	53.8	0	125	154	0	29	29
2025	11	17	9	10	0	26.4	-1.5	0.973	0.5	0.4	0	41.3	53.8	0	124	153	0	28	28
2025	11	17	9	20	0	27.7	-0.8	0.972	0.5	0.5	0	41.3	53.3	0	124	153	0	28	29
2025	11	17	9	30	0	27.1	-0.5	0.972	0.4	0.3	0	41.3	53.3	0	124	153	0	28	29
2025	11	17	9	40	0	26.1	-0.7	0.972	0.5	0.4	0	40.9	53.3	0	124	153	0	29	29
2025	11	17	9	50	0	26.7	-2.4	0.972	0.3	0.2	0	41.3	53.8	0	124	153	0	28	28
2025	11	17	10	0	0	26.6	-1.5	0.971	0.4	0.3	0	40.9	53.3	0	123	152	0	28	28
2025	11	17	10	10	0	26.5	-0.8	0.971	0.5	0.4	0	40.9	52.9	0	123	152	0	28	29
2025	11	17	10	20	0	26.8	-2.3	0.971	0.4	0.3	0	40.9	52.9	0	123	152	0	28	29
2025	11	17	10	30	0	27.4	-1.8	0.971	0.5	0.5	0	40.9	52.9	0	123	152	0	28	29
2025	11	17	10	40	0	27.2	-1.5	0.971	0.6	0.5	0	40.9	52.5	0	123	151	0	28	29
2025	11	17	10	50	0	26.7	-1.5	0.97	0.4	0.3	0	40.9	52.9	0	123	151	0	28	28
2025	11	17	11	0	0	27	-2.4	0.97	0.5	0.4	0	40	52.5	0	122	151	0	29	29
2025	11	17	11	10	0	28	-1.7	0.97	0.5	0.4	0	40.4	52.5	0	122	151	0	28	29
2025	11	17	11	20	0	27.8	-2.2	0.97	0.5	0.4	0	40.4	52.9	0	122	151	0	28	28
2025	11	17	11	30	0	26.4	-2.5	0.97	0.5	0.4	0	40.4	52.9	0	122	151	0	28	28
2025	11	17	11	40	0	26	-2.5	0.97	0.5	0.4	0	40.9	52.9	0	122	151	0	27	28
2025	11	17	11	50	0	26.6	-2	0.97	0.5	0.5	0	40.4	52.5	0	122	151	0	28	29
2025	11	17	12	0	0	26.6	-2.3	0.97	0.4	0.3	0	40	52.9	0	121	151	0	28	28
2025	11	17	12	10	0	26.6	-2.6	0.97	0.5	0.4	0	40	52.9	0	121	151	0	28	28
2025	11	17	12	20	0	27.6	-2.3	0.969	0.5	0.5	0	40.4	52	0	121	150	0	27	29
2025	11	17	12	30	0	28	-0.6	0.969	0.5	0.4	0	40.4	52.5	0	121	150	0	27	28
2025	11	17	12	40	0	27.4	-1.8	0.968	0.4	0.3	0	39.6	52	0	120	150	0	28	29
2025	11	17	12	50	0	26.2	-2.1	0.969	0.5	0.4	0	39.6	52.5	0	120	150	0	28	28
2025	11	17	13	0	0	26.2	-1.9	0.968	0.5	0.5	0	39.6	51.6	0	120	149	0	28	29
2025	11	17	13	10	0	26.8	-1.4	0.967	0.4	0.3	0	39.6	52.5	0	120	150	0	28	28
2025	11	17	13	20	0	26.5	-2.1	0.967	0.5	0.4	0	39.6	52	0	120	149	0	28	28
2025	11	17	13	30	0	26	-2.2	0.967	0.5	0.5	0	39.6	52	0	120	149	0	28	28
2025	11	17	13	40	0	26.4	-1.2	0.967	0.5	0.5	0	39.6	52	0	120	150	0	28	29
2025	11	17	13	50	0	26.2	-2.7	0.966	0.5	0.4	0	39.6	52	0	120	149	0	28	28
2025	11	17	14	0	0	26.8	-3	0.965	0.5	0.4	0	39.6	51.6	0	120	149	0	28	29
2025	11	17	14	10	0	26.6	-2.8	0.966	0.5	0.5	0	39.6	52	0	120	149	0	28	28
2025	11	17	14	20	0	26.6	-1.7	0.965	0.5	0.4	0	39.1	52	0	119	149	0	28	28
2025	11	17	14	30	0	25.9	-1.9	0.965	0.4	0.3	0	39.1	51.6	0	119	149	0	28	29
2025	11	17	14	40	0	26.5	-2.3	0.964	0.3	0.2	0	39.1	51.6	0	119	148	0	28	28
2025	11	17	14	50	0	26.6	-1	0.964	0.4	0.3	0	39.1	51.2	0	119	148	0	28	29
2025	11	17	15	0	0	25.8	-1.8	0.964	0.4	0.3	0	39.1	51.2	0	119	148	0	28	29
2025	11	17	15	10	0	27.1	-1.3	0.964	0.5	0.4	0	38.7	51.6	0	118	148	0	28	28
2025	11	17	15	20	0	26.9	-1.8	0.965	0.3	0.2	0	38.7	51.2	0	118	148	0	28	29
2025	11	17	15	30	0	25.6	-2.5	0.963	0.5	0.4	0	38.7	50.7	0	118	147	0	28	29
2025	11	17	15	40	0	25.8	-1.5	0.962	0.4	0.3	0	39.1	51.6	0	119	148	0	28	28
2025	11	17	15	50	0	26.5	-2.6	0.962	0.5	0.4	0	38.7	50.7	0	118	147	0	28	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	17	16	0	0	26.4	-3	0.963	0.5	0.4	0	38.7	50.7	0	118	147	0	28	29
2025	11	17	16	10	0	26.5	-2.5	0.962	0.5	0.5	0	38.3	51.2	0	117	147	0	28	28
2025	11	17	16	20	0	26	-2	0.962	0.5	0.4	0	38.3	50.7	0	117	146	0	28	28
2025	11	17	16	30	0	26.8	-2.6	0.961	0.5	0.4	0	38.3	50.7	0	117	146	0	28	28
2025	11	17	16	40	0	26	-2.3	0.962	0.4	0.3	0	37.8	50.3	0	116	146	0	28	29
2025	11	17	16	50	0	26.1	-2.3	0.961	0.5	0.4	0	37.8	50.3	0	116	145	0	28	28
2025	11	17	17	0	0	27.6	-1.7	0.961	0.6	0.5	0	37.8	50.3	0	116	145	0	28	28
2025	11	17	17	10	0	26.4	-1.9	0.961	0.4	0.3	0	37.8	50.3	0	116	145	0	28	28
2025	11	17	17	20	0	26	-1.8	0.961	0.3	0.2	0	38.3	50.3	0	116	145	0	27	28
2025	11	17	17	30	0	25.9	-2.4	0.961	0.4	0.3	0	37.4	49.9	0	115	145	0	28	29
2025	11	17	17	40	0	26.1	-2	0.961	0.5	0.4	0	37.8	50.7	0	116	146	0	28	28
2025	11	17	17	50	0	25.6	-3	0.96	0.4	0.3	0	37.8	50.3	0	116	145	0	28	28
2025	11	17	18	0	0	26	-2.3	0.96	0.5	0.5	0	37.4	50.3	0	115	145	0	28	28
2025	11	17	18	10	0	25.5	-2.5	0.96	0.3	0.2	0	37.4	49.9	0	115	144	0	28	28
2025	11	17	18	20	0	25.5	-1.8	0.96	0.4	0.3	0	37.4	49.9	0	115	145	0	28	29
2025	11	17	18	30	0	26.4	-2.2	0.959	0.4	0.3	0	37.8	49.9	0	116	145	0	28	29
2025	11	17	18	40	0	25.7	-0.8	0.959	0.5	0.4	0	37.8	50.7	0	116	146	0	28	28
2025	11	17	18	50	0	25.4	-1.9	0.959	0.4	0.3	0	37.8	50.3	0	116	146	0	28	29
2025	11	17	19	0	0	25.5	-1.7	0.959	0.5	0.4	0	37.8	50.3	0	116	145	0	28	28
2025	11	17	19	10	0	25.5	-1.5	0.959	0.4	0.3	0	38.3	50.7	0	117	146	0	28	28
2025	11	17	19	20	0	25.8	-2	0.959	0.5	0.4	0	37.4	50.3	0	115	145	0	28	28
2025	11	17	19	30	0	26.2	-0.9	0.959	0.4	0.3	0	37.4	49.9	0	115	145	0	28	29
2025	11	17	19	40	0	26.9	-1.7	0.959	0.4	0.3	0	37.4	49.9	0	115	145	0	28	29
2025	11	17	19	50	0	25.1	-1.6	0.959	0.4	0.3	0	37.8	50.3	0	115	145	0	27	28
2025	11	17	20	0	0	26.3	-2.6	0.958	0.4	0.3	0	37.4	49.5	0	115	144	0	28	29
2025	11	17	20	10	0	25.1	-2.5	0.958	0.5	0.4	0	37.4	50.3	0	115	145	0	28	28
2025	11	17	20	20	0	25.6	-2.7	0.957	0.4	0.3	0	37.4	49.5	0	115	144	0	28	29
2025	11	17	20	30	0	26.5	-2.5	0.958	0.5	0.5	0	37.4	49.9	0	115	144	0	28	28
2025	11	17	20	40	0	25.6	-2.1	0.958	0.5	0.5	0	37	49.9	0	115	144	0	29	28
2025	11	17	20	50	0	26	-2	0.957	0.4	0.3	0	37	49.9	0	115	145	0	29	29
2025	11	17	21	0	0	25.8	-2.6	0.957	0.4	0.3	0	37.4	50.3	0	115	145	0	28	28
2025	11	17	21	10	0	26.5	-2.8	0.957	0.5	0.5	0	37.4	49.9	0	115	145	0	28	29
2025	11	17	21	20	0	25.5	-1.8	0.956	0.3	0.2	0	37.4	50.3	0	115	145	0	28	28
2025	11	17	21	30	0	26.9	-2	0.955	0.6	0.5	0	38.3	50.7	0	117	147	0	28	29
2025	11	17	21	40	0	25.7	-1.6	0.955	0.4	0.3	0	39.1	52	0	119	149	0	28	28
2025	11	17	21	50	0	26.5	-1	0.955	0.4	0.3	0	40	52	0	121	150	0	28	29
2025	11	17	22	0	0	26	-1.9	0.956	0.5	0.4	0	40	52.9	0	121	151	0	28	28
2025	11	17	22	10	0	26.9	-1.7	0.957	0.5	0.4	0	40	52.5	0	121	151	0	28	29
2025	11	17	22	20	0	25.8	-2.1	0.957	0.5	0.5	0	40	52	0	121	150	0	28	29
2025	11	17	22	30	0	26.7	-2.4	0.956	0.5	0.4	0	40	52.5	0	121	151	0	28	29
2025	11	17	22	40	0	25.3	-3	0.957	0.4	0.3	0	38.7	52	0	119	149	0	29	28
2025	11	17	22	50	0	25.5	-2.1	0.957	0.5	0.4	0	40.4	52.5	0	122	151	0	28	29
2025	11	17	23	0	0	26.9	-1.8	0.956	0.3	0.2	0	40.4	53.3	0	122	152	0	28	28
2025	11	17	23	10	0	26	-2	0.956	0.5	0.5	0	40.9	53.8	0	123	153	0	28	28
2025	11	17	23	20	0	25.9	-1.6	0.955	0.5	0.4	0	40.9	53.3	0	123	153	0	28	29
2025	11	17	23	30	0	26.5	-1.7	0.956	0.5	0.4	0	40.4	53.3	0	122	152	0	28	28
2025	11	17	23	40	0	26.8	-2.5	0.956	0.4	0.3	0	40.4	52.9	0	121	151	0	27	28
2025	11	17	23	50	0	25.4	-2.5	0.957	0.5	0.4	0	39.6	52.5	0	120	150	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	18	0	0	0	26.5	-2.6	0.957	0.5	0.4	0	39.6	52	0	119	149	0	27	28
2025	11	18	0	10	0	25	-1.8	0.957	0.5	0.4	0	39.1	52	0	119	149	0	28	28
2025	11	18	0	20	0	25.1	-1.6	0.957	0.4	0.3	0	39.1	51.6	0	119	149	0	28	29
2025	11	18	0	30	0	25.7	-0.6	0.956	0.5	0.4	0	39.1	52	0	119	149	0	28	28
2025	11	18	0	40	0	25.8	-1.7	0.956	0.4	0.3	0	38.7	51.6	0	118	148	0	28	28
2025	11	18	0	50	0	25.9	-1.7	0.956	0.5	0.4	0	39.1	51.6	0	118	148	0	27	28
2025	11	18	1	0	0	25.4	-1.6	0.956	0.5	0.4	0	38.7	51.6	0	118	148	0	28	28
2025	11	18	1	10	0	25.8	-1.7	0.956	0.4	0.3	0	38.7	51.6	0	118	148	0	28	28
2025	11	18	1	20	0	25.4	-1.2	0.956	0.5	0.4	0	38.7	51.2	0	118	148	0	28	29
2025	11	18	1	30	0	25.6	-1	0.955	0.5	0.4	0	38.3	51.2	0	117	147	0	28	28
2025	11	18	1	40	0	25.4	-1.7	0.955	0.5	0.4	0	38.3	50.7	0	117	147	0	28	29
2025	11	18	1	50	0	24.2	-0.8	0.955	0.4	0.3	0	38.3	51.2	0	117	147	0	28	28
2025	11	18	2	0	0	24.3	-1.6	0.955	0.3	0.2	0	38.3	51.2	0	117	147	0	28	28
2025	11	18	2	10	0	25.8	-2	0.955	0.4	0.3	0	38.3	51.2	0	117	147	0	28	28
2025	11	18	2	20	0	25	-0.8	0.954	0.5	0.4	0	38.3	51.2	0	117	147	0	28	28
2025	11	18	2	30	0	25.3	-0.4	0.954	0.4	0.3	0	38.3	51.6	0	117	148	0	28	28
2025	11	18	2	40	0	24.6	-1.6	0.954	0.5	0.4	0	38.3	51.2	0	117	147	0	28	28
2025	11	18	2	50	0	24.7	-1.6	0.954	0.4	0.3	0	38.7	51.6	0	118	148	0	28	28
2025	11	18	3	0	0	26.7	-2.8	0.954	0.5	0.4	0	38.3	51.2	0	117	147	0	28	28
2025	11	18	3	10	0	26.4	-1.9	0.954	0.4	0.3	0	38.3	51.2	0	117	147	0	28	28
2025	11	18	3	20	0	26.6	-1.8	0.953	0.5	0.4	0	37.8	51.2	0	116	147	0	28	28
2025	11	18	3	30	0	25.7	-2.1	0.953	0.3	0.2	0	38.3	50.7	0	117	147	0	28	29
2025	11	18	3	40	0	25.2	-1.7	0.953	0.5	0.4	0	38.3	51.2	0	117	147	0	28	28
2025	11	18	3	50	0	26.4	-1.5	0.953	0.5	0.4	0	37.8	50.3	0	116	146	0	28	29
2025	11	18	4	0	0	24.5	-1.2	0.952	0.4	0.3	0	37.8	51.2	0	116	147	0	28	28
2025	11	18	4	10	0	25	-1.8	0.951	0.4	0.3	0	37.8	50.3	0	116	146	0	28	29
2025	11	18	4	20	0	25.8	-1.9	0.951	0.5	0.4	0	37.4	50.3	0	116	146	0	29	29
2025	11	18	4	30	0	24.8	-2	0.951	0.5	0.4	0	37.8	50.3	0	116	146	0	28	29
2025	11	18	4	40	0	26	-1.6	0.951	0.4	0.3	0	37.8	50.7	0	116	146	0	28	28
2025	11	18	4	50	0	26	-2.1	0.95	0.5	0.4	0	37.4	50.7	0	116	146	0	29	28
2025	11	18	5	0	0	24.5	-1.2	0.95	0.5	0.4	0	38.3	50.3	0	117	146	0	28	29
2025	11	18	5	10	0	25	-1.6	0.95	0.5	0.4	0	37.8	50.3	0	116	146	0	28	29
2025	11	18	5	20	0	26.2	-1.7	0.95	0.5	0.5	0	37.8	50.3	0	116	146	0	28	29
2025	11	18	5	30	0	25.3	-1.8	0.95	0.4	0.3	0	37.8	50.3	0	116	146	0	28	29
2025	11	18	5	40	0	25.8	-0.3	0.949	0.4	0.3	0	37.8	50.3	0	116	146	0	28	29
2025	11	18	5	50	0	25.4	-1.8	0.95	0.5	0.5	0	37.8	50.7	0	116	146	0	28	28
2025	11	18	6	0	0	25.9	-2	0.949	0.5	0.4	0	37.4	49.5	0	115	145	0	28	30
2025	11	18	6	10	0	26	-1.4	0.949	0.4	0.3	0	37.8	50.7	0	116	146	0	28	28
2025	11	18	6	20	0	25.8	-1	0.949	0.5	0.4	0	37.4	50.3	0	116	146	0	29	29
2025	11	18	6	30	0	25.5	-2.2	0.949	0.4	0.3	0	37.8	50.3	0	116	146	0	28	29
2025	11	18	6	40	0	25.7	-2	0.949	0.4	0.3	0	37.8	50.7	0	116	147	0	28	29
2025	11	18	6	50	0	24.5	-1.3	0.949	0.5	0.4	0	37.8	50.3	0	116	146	0	28	29
2025	11	18	7	0	0	25.8	-0.7	0.949	0.4	0.3	0	37.4	49.9	0	115	145	0	28	29
2025	11	18	7	10	0	25.4	-1.3	0.949	0.5	0.5	0	37.4	49.9	0	115	145	0	28	29
2025	11	18	7	20	0	26.2	-2.8	0.949	0.4	0.3	0	37.4	49.9	0	115	145	0	28	29
2025	11	18	7	30	0	25.9	-3.3	0.949	0.5	0.4	0	37.4	49.9	0	115	145	0	28	29
2025	11	18	7	40	0	25.4	-1.8	0.949	0.5	0.4	0	37	50.3	0	115	145	0	29	28
2025	11	18	7	50	0	25.6	-2	0.949	0.5	0.4	0	37.8	49.9	0	115	145	0	27	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	18	8	0	0	25.7	-2.7	0.949	0.5	0.4	0	36.5	49.5	0	113	144	0	28	29
2025	11	18	8	10	0	24.9	-1.8	0.949	0.6	0.5	0	37	49.5	0	114	144	0	28	29
2025	11	18	8	20	0	24.7	-2.4	0.949	0.5	0.5	0	36.5	49	0	113	143	0	28	29
2025	11	18	8	30	0	24.4	-2.7	0.949	0.5	0.5	0	36.1	49	0	112	142	0	28	28
2025	11	18	8	40	0	25.5	-1.7	0.948	0.5	0.4	0	36.1	48.6	0	112	142	0	28	29
2025	11	18	8	50	0	24.4	-2.4	0.948	0.4	0.3	0	35.7	48.2	0	111	141	0	28	29
2025	11	18	9	0	0	25.3	-1.5	0.948	0.4	0.3	0	34.8	47.7	0	110	140	0	29	29
2025	11	18	9	10	0	25.2	-2.4	0.948	0.5	0.4	0	35.3	48.2	0	110	140	0	28	28
2025	11	18	9	20	0	25.2	-1.9	0.949	0.4	0.3	0	35.3	47.3	0	110	139	0	28	29
2025	11	18	9	30	0	25.2	-1.7	0.948	0.5	0.4	0	35.3	47.7	0	110	140	0	28	29
2025	11	18	9	40	0	24.6	-1.2	0.949	0.5	0.4	0	35.3	47.7	0	110	140	0	28	29
2025	11	18	9	50	0	25	-2.4	0.949	0.4	0.3	0	34.8	47.7	0	109	139	0	28	28
2025	11	18	10	0	0	24.9	-2.1	0.949	0.5	0.4	0	34.4	46.9	0	108	138	0	28	29
2025	11	18	10	10	0	26.3	-2.5	0.949	0.5	0.5	0	34	46.4	0	107	137	0	28	29
2025	11	18	10	20	0	25.7	-2.6	0.949	0.4	0.3	0	34	46.4	0	107	137	0	28	29
2025	11	18	10	30	0	25.3	-1.3	0.949	0.3	0.2	0	34	46.4	0	108	137	0	29	29
2025	11	18	10	40	0	24.3	-1.8	0.949	0.4	0.3	0	34	46.9	0	107	137	0	28	28
2025	11	18	10	50	0	25.5	-1.4	0.949	0.4	0.3	0	34	46.9	0	107	137	0	28	28
2025	11	18	11	0	0	24.9	-1.8	0.949	0.5	0.4	0	34.4	46.9	0	108	138	0	28	29
2025	11	18	11	10	0	24.8	-1.6	0.949	0.5	0.4	0	34	46	0	107	136	0	28	29
2025	11	18	11	20	0	25.4	-2	0.949	0.5	0.4	0	33.5	46.9	0	107	137	0	29	28
2025	11	18	11	30	0	24.6	-2.1	0.949	0.4	0.3	0	34	46.9	0	107	137	0	28	28
2025	11	18	11	40	0	25.8	-1.8	0.949	0.5	0.5	0	33.5	46.4	0	107	137	0	29	29
2025	11	18	11	50	0	24.9	-1.2	0.949	0.5	0.4	0	33.1	46	0	106	136	0	29	29
2025	11	18	12	0	0	26.1	-2.3	0.949	0.4	0.3	0	33.5	46	0	107	136	0	29	29
2025	11	18	12	10	0	24.3	-2	0.949	0.5	0.4	0	34	46.9	0	107	137	0	28	28
2025	11	18	12	20	0	24.6	-1.5	0.949	0.3	0.2	0	34	46.4	0	107	137	0	28	29
2025	11	18	12	30	0	27	-2.5	0.949	0.4	0.3	0	33.5	46	0	106	136	0	28	29
2025	11	18	12	40	0	24.3	-1.8	0.949	0.5	0.4	0	34	46.4	0	108	137	0	29	29
2025	11	18	12	50	0	24.9	-2.1	0.949	0.4	0.3	0	34.8	46.9	0	109	138	0	28	29
2025	11	18	13	0	0	25.5	-2.7	0.949	0.4	0.3	0	35.3	46.9	0	109	138	0	27	29
2025	11	18	13	10	0	25.5	-2.5	0.949	0.4	0.3	0	36.1	48.6	0	112	142	0	28	29
2025	11	18	13	20	0	24.4	-2.2	0.949	0.5	0.4	0	37	49.5	0	114	144	0	28	29
2025	11	18	13	30	0	25	-2	0.949	0.5	0.4	0	37	49.9	0	114	144	0	28	28
2025	11	18	13	40	0	25.2	-1.7	0.949	0.5	0.4	0	35.7	48.6	0	111	141	0	28	28
2025	11	18	13	50	0	25.8	-2.2	0.949	0.4	0.3	0	36.1	48.6	0	112	141	0	28	28
2025	11	18	14	1	10	24.3	-1.5	0.949	0.5	0.4	0	47.3	49.5	0	138	144	0	28	29
2025	11	18	14	11	10	25.9	-2	0.949	0.5	0.4	0	48.2	49	0	140	143	0	28	29
2025	11	18	14	21	10	26.6	-1.6	0.949	0.4	0.3	0	48.2	49.5	0	140	143	0	28	28
2025	11	18	14	31	10	25.7	-2.4	0.949	0.5	0.5	0	47.7	48.6	0	139	142	0	28	29
2025	11	18	14	41	10	26.2	-0.8	0.949	0.5	0.4	0	46.9	48.2	0	138	141	0	29	29
2025	11	18	14	51	10	25	-1.8	0.95	0.3	0.2	0	47.3	48.2	0	138	141	0	28	29
2025	11	18	15	1	10	25.8	-1.5	0.95	0.5	0.4	0	47.7	49	0	139	142	0	28	28
2025	11	18	15	11	10	27	-1.2	0.951	0.4	0.3	0	48.6	49.5	0	141	144	0	28	29
2025	11	18	15	21	10	25.5	-1.9	0.952	0.4	0.3	0	49.5	50.3	0	143	145	0	28	28
2025	11	18	15	31	10	25.1	-1.6	0.953	0.5	0.4	0	49.9	50.7	0	144	146	0	28	28
2025	11	18	15	41	10	25.4	-0.4	0.953	0.5	0.4	0	49.5	50.3	0	144	146	0	29	29
2025	11	18	15	51	10	26.2	-2.1	0.953	0.5	0.4	0	49	50.3	0	142	145	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	18	16	1	10	26	-1.4	0.954	0.5	0.4	0	49	49.5	0	142	144	0	28	29
2025	11	18	16	11	10	25	-1.1	0.953	0.5	0.5	0	48.2	49.5	0	140	143	0	28	28
2025	11	18	16	21	10	25.6	-2	0.954	0.5	0.5	0	47.7	48.6	0	139	142	0	28	29
2025	11	18	16	31	10	25.7	-0.9	0.954	0.4	0.3	0	47.3	48.6	0	138	141	0	28	28
2025	11	18	16	41	10	26.5	-0.9	0.954	0.4	0.3	0	47.3	48.2	0	138	141	0	28	29
2025	11	18	16	51	10	25.8	-1	0.954	0.5	0.4	0	47.3	48.6	0	138	141	0	28	28
2025	11	18	17	1	10	26.2	-2.1	0.955	0.5	0.5	0	46.4	47.7	0	136	140	0	28	29
2025	11	18	17	11	10	25.5	-0.9	0.955	0.4	0.3	0	46	47.7	0	136	139	0	29	28
2025	11	18	17	21	10	25.8	-0.9	0.955	0.5	0.4	0	46	47.3	0	136	139	0	29	29
2025	11	18	17	31	10	25.6	-2	0.955	0.5	0.4	0	46.9	48.2	0	137	140	0	28	28
2025	11	18	17	41	10	25	-1.4	0.955	0.4	0.3	0	46.9	47.7	0	137	139	0	28	28
2025	11	18	17	51	10	26.5	-1.2	0.955	0.5	0.4	0	46	46.9	0	135	138	0	28	29
2025	11	18	18	1	10	25.4	-3.3	0.956	0.5	0.4	0	46	46.9	0	135	138	0	28	29
2025	11	18	18	11	10	26	-1.1	0.956	0.7	0.6	0	46.4	47.3	0	136	139	0	28	29
2025	11	18	18	21	10	26.1	-1	0.956	0.3	0.2	0	46.4	47.3	0	136	139	0	28	29
2025	11	18	18	31	10	26.2	-2.5	0.956	0.4	0.3	0	46.4	47.7	0	136	139	0	28	28
2025	11	18	18	41	10	26.2	-2.5	0.956	0.5	0.4	0	46.4	47.3	0	137	139	0	29	29
2025	11	18	18	51	10	26.2	-1.4	0.956	0.4	0.3	0	46.9	47.7	0	137	140	0	28	29
2025	11	18	19	1	10	25.3	-2	0.956	0.5	0.4	0	46.9	48.2	0	137	140	0	28	28
2025	11	18	19	11	10	26.5	-1.4	0.956	0.4	0.3	0	46.9	47.7	0	137	140	0	28	29
2025	11	18	19	21	10	25.7	-1.6	0.957	0.4	0.3	0	46.9	48.2	0	137	140	0	28	28
2025	11	18	19	31	10	25.9	-1.8	0.957	0.5	0.4	0	46.9	48.2	0	137	140	0	28	28
2025	11	18	19	41	10	25.8	-1.2	0.957	0.4	0.3	0	46.9	48.6	0	137	141	0	28	28
2025	11	18	19	51	10	25.8	-1	0.957	0.4	0.3	0	47.3	48.6	0	138	141	0	28	28
2025	11	18	20	1	10	26.3	-1.6	0.957	0.4	0.3	0	47.3	48.2	0	138	141	0	28	29
2025	11	18	20	11	10	25.9	-1.6	0.957	0.5	0.4	0	47.7	49	0	139	142	0	28	28
2025	11	18	20	21	10	26.8	-1.9	0.957	0.3	0.2	0	47.7	48.6	0	139	142	0	28	29
2025	11	18	20	31	10	25	-1.6	0.957	0.4	0.3	0	47.7	48.6	0	139	142	0	28	29
2025	11	18	20	41	10	25.8	-0.1	0.957	0.4	0.3	0	47.7	48.6	0	139	142	0	28	29
2025	11	18	20	51	10	26.2	-1.7	0.958	0.5	0.4	0	47.7	49	0	139	142	0	28	28
2025	11	18	21	1	10	26.6	-1.7	0.958	0.5	0.4	0	47.7	48.6	0	139	142	0	28	29
2025	11	18	21	11	10	26.1	-1.6	0.958	0.5	0.4	0	47.7	48.6	0	139	142	0	28	29
2025	11	18	21	21	10	26.2	-1.9	0.958	0.5	0.4	0	47.7	49	0	139	142	0	28	28
2025	11	18	21	31	10	25.7	-1.6	0.958	0.5	0.4	0	48.2	48.6	0	140	142	0	28	29
2025	11	18	21	41	10	26.5	-1.4	0.959	0.4	0.3	0	47.7	48.6	0	139	142	0	28	29
2025	11	18	21	51	10	26	-2.9	0.959	0.5	0.4	0	47.7	49	0	139	142	0	28	28
2025	11	18	22	1	10	27.1	-1.9	0.959	0.4	0.3	0	47.7	48.6	0	139	142	0	28	29
2025	11	18	22	11	10	25.4	-2.3	0.959	0.5	0.4	0	47.7	48.6	0	139	142	0	28	29
2025	11	18	22	21	10	25.9	-2	0.96	0.4	0.3	0	47.7	49	0	139	142	0	28	28
2025	11	18	22	31	10	24.9	-2.1	0.961	0.4	0.3	0	48.2	49	0	140	143	0	28	29
2025	11	18	22	41	10	26.5	-1.8	0.963	0.5	0.4	0	48.2	49	0	140	143	0	28	29
2025	11	18	22	51	10	26.3	-1.9	0.964	0.5	0.5	0	48.2	49.5	0	140	143	0	28	28
2025	11	18	23	1	10	27.1	-1.1	0.964	0.5	0.4	0	47.7	49	0	139	143	0	28	29
2025	11	18	23	11	10	26.4	-1.8	0.965	0.3	0.2	0	47.3	49.5	0	139	143	0	29	28
2025	11	18	23	21	10	26.5	-1.2	0.965	0.5	0.4	0	48.2	49	0	140	143	0	28	29
2025	11	18	23	31	10	26.8	-2.4	0.965	0.5	0.4	0	47.7	48.6	0	139	142	0	28	29
2025	11	18	23	41	10	25.9	-1.5	0.966	0.5	0.4	0	48.2	49	0	140	143	0	28	29
2025	11	18	23	51	10	26.5	-1.6	0.966	0.4	0.3	0	47.3	49.5	0	139	143	0	29	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	19	0	1	10	26.3	-2	0.967	0.4	0.3	0	48.2	49	0	140	143	0	28	29
2025	11	19	0	11	10	26.6	-1.7	0.967	0.5	0.4	0	47.7	49	0	139	143	0	28	29
2025	11	19	0	21	10	26.9	-1.7	0.967	0.5	0.4	0	47.7	49.5	0	139	143	0	28	28
2025	11	19	0	31	10	26.8	-1.6	0.967	0.3	0.2	0	47.7	48.6	0	139	142	0	28	29
2025	11	19	0	41	10	26.3	-2	0.967	0.4	0.3	0	47.7	48.6	0	140	142	0	29	29
2025	11	19	0	51	10	25.4	-2.1	0.967	0.5	0.4	0	47.7	49	0	139	142	0	28	28
2025	11	19	1	1	10	27.1	-1.9	0.968	0.5	0.4	0	47.7	48.6	0	139	142	0	28	29
2025	11	19	1	11	10	25.7	-1.6	0.968	0.3	0.2	0	47.7	49	0	139	143	0	28	29
2025	11	19	1	21	10	26.4	-2.4	0.968	0.3	0.2	0	47.7	49	0	140	143	0	29	29
2025	11	19	1	31	10	26.2	-2	0.968	0.4	0.3	0	47.7	48.6	0	139	142	0	28	29
2025	11	19	1	41	10	26.7	-1.5	0.969	0.5	0.4	0	47.7	48.6	0	139	142	0	28	29
2025	11	19	1	51	10	27.2	-1.8	0.969	0.4	0.3	0	47.7	48.6	0	139	142	0	28	29
2025	11	19	2	1	10	26.8	-1.7	0.969	0.5	0.4	0	47.7	48.6	0	139	142	0	28	29
2025	11	19	2	11	10	26.9	-2.7	0.969	0.4	0.3	0	47.7	48.6	0	139	142	0	28	29
2025	11	19	2	21	10	27.5	-1.2	0.97	0.4	0.3	0	47.7	48.6	0	139	142	0	28	29
2025	11	19	2	31	10	26.8	-2.7	0.97	0.4	0.3	0	47.7	48.6	0	139	142	0	28	29
2025	11	19	2	41	10	26.6	-1.6	0.97	0.3	0.2	0	47.7	48.2	0	139	142	0	28	30
2025	11	19	2	51	10	26.3	-2	0.971	0.4	0.3	0	47.3	48.6	0	139	142	0	29	29
2025	11	19	3	1	10	27.5	-1.6	0.972	0.3	0.2	0	47.7	48.6	0	139	142	0	28	29
2025	11	19	3	11	10	27.2	-1.8	0.973	0.5	0.5	0	47.7	48.2	0	139	142	0	28	30
2025	11	19	3	21	10	26.1	-1.9	0.974	0.4	0.3	0	47.7	48.6	0	139	142	0	28	29
2025	11	19	3	31	10	26.3	-1.4	0.975	0.4	0.3	0	47.7	49	0	139	142	0	28	28
2025	11	19	3	41	10	27.7	-2.4	0.975	0.5	0.4	0	47.7	48.6	0	139	142	0	28	29
2025	11	19	3	51	10	27.2	-2.2	0.975	0.3	0.2	0	47.7	48.6	0	139	142	0	28	29
2025	11	19	4	1	10	26.6	-2	0.976	0.5	0.4	0	47.7	49	0	139	143	0	28	29
2025	11	19	4	11	10	26.5	-1.8	0.976	0.5	0.4	0	47.3	48.6	0	139	142	0	29	29
2025	11	19	4	21	10	27.5	-2.6	0.976	0.3	0.2	0	47.7	49	0	139	143	0	28	29
2025	11	19	4	31	10	26.8	-2.4	0.977	0.4	0.3	0	48.2	49.5	0	140	143	0	28	28
2025	11	19	4	41	10	27.2	-2.1	0.977	0.5	0.5	0	49	49.9	0	141	144	0	27	28
2025	11	19	4	51	10	26.7	-1.4	0.977	0.4	0.3	0	49	49.9	0	142	145	0	28	29
2025	11	19	5	1	10	27.3	-2	0.977	0.5	0.4	0	49.5	50.7	0	143	146	0	28	28
2025	11	19	5	11	10	27.2	-2.4	0.977	0.4	0.3	0	49.9	50.7	0	144	147	0	28	29
2025	11	19	5	21	10	26.5	-1.5	0.978	0.5	0.4	0	50.3	51.2	0	145	148	0	28	29
2025	11	19	5	31	10	28.1	-1.5	0.978	0.5	0.5	0	50.3	51.2	0	145	148	0	28	29
2025	11	19	5	41	10	27.3	-1.2	0.978	0.4	0.3	0	50.3	51.6	0	145	148	0	28	28
2025	11	19	5	51	10	27.5	-2.4	0.978	0.5	0.4	0	49.5	51.2	0	143	148	0	28	29
2025	11	19	6	1	10	27.4	-1.9	0.978	0.4	0.3	0	49.5	50.7	0	144	147	0	29	29
2025	11	19	6	11	10	27.9	-2.4	0.978	0.5	0.5	0	49.5	50.7	0	143	147	0	28	29
2025	11	19	6	21	10	28	-1.7	0.978	0.5	0.5	0	49.5	50.7	0	144	147	0	29	29
2025	11	19	6	31	10	27.4	-1.1	0.978	0.5	0.5	0	49.5	51.2	0	144	147	0	29	28
2025	11	19	6	41	10	25.7	-0.8	0.978	0.5	0.5	0	49.5	51.2	0	144	147	0	29	28
2025	11	19	6	51	10	26.7	-1.6	0.978	0.5	0.4	0	50.3	51.6	0	145	148	0	28	28
2025	11	19	7	1	10	27.3	-0.2	0.979	0.4	0.3	0	50.3	51.2	0	145	148	0	28	29
2025	11	19	7	11	10	26.7	-0.8	0.978	0.3	0.2	0	50.3	51.2	0	145	148	0	28	29
2025	11	19	7	21	10	27.9	-1.8	0.978	0.4	0.3	0	50.7	51.6	0	146	149	0	28	29
2025	11	19	7	31	10	27.9	-1.5	0.978	0.5	0.4	0	50.7	52	0	146	150	0	28	29
2025	11	19	7	41	10	27.1	-0.8	0.978	0.4	0.3	0	50.7	52	0	146	149	0	28	28
2025	11	19	7	51	10	27.1	-2.3	0.978	0.5	0.4	0	50.3	52	0	146	149	0	29	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	19	8	1	10	28.5	-0.4	0.978	0.3	0.2	0	50.7	51.6	0	146	149	0	28	29
2025	11	19	8	11	10	26.3	-1.1	0.978	0.4	0.3	0	50.7	52.5	0	146	150	0	28	28
2025	11	19	8	21	10	27.7	-1.4	0.978	0.5	0.4	0	50.7	52	0	146	150	0	28	29
2025	11	19	8	31	10	27.9	-1.2	0.978	0.5	0.4	0	50.7	52	0	147	150	0	29	29
2025	11	19	8	41	10	27.2	-0.3	0.978	0.5	0.5	0	51.2	52.5	0	147	151	0	28	29
2025	11	19	8	51	10	28	-2	0.978	0.5	0.4	0	51.2	52.5	0	148	151	0	29	29
2025	11	19	9	1	10	27.9	-1.1	0.978	0.4	0.3	0	52	53.3	0	149	153	0	28	29
2025	11	19	9	11	10	26.8	0	0.978	0.3	0.2	0	52.5	53.3	0	150	153	0	28	29
2025	11	19	9	21	10	27.6	-1.6	0.978	0.5	0.4	0	52.5	53.3	0	150	153	0	28	29
2025	11	19	9	31	10	26.1	-1.1	0.978	0.5	0.5	0	52.5	53.8	0	151	154	0	29	29
2025	11	19	9	41	10	26.4	-2.4	0.978	0.5	0.5	0	52.9	54.2	0	151	155	0	28	29
2025	11	19	9	51	10	28.5	-1.6	0.978	0.4	0.3	0	53.3	54.6	0	152	155	0	28	28
2025	11	19	10	1	10	26.4	-0.9	0.978	0.4	0.3	0	53.8	54.6	0	153	156	0	28	29
2025	11	19	10	11	10	25.9	-0.9	0.978	0.3	0.2	0	53.8	55	0	153	156	0	28	28
2025	11	19	10	21	10	25.6	0	0.977	0.5	0.4	0	53.3	54.6	0	153	156	0	29	29
2025	11	19	10	31	10	26.3	-0.8	0.977	0.4	0.3	0	53.8	54.6	0	153	156	0	28	29
2025	11	19	10	41	10	26.2	-0.5	0.977	0.5	0.4	0	54.2	55	0	154	157	0	28	29
2025	11	19	10	51	10	27.1	-0.7	0.977	0.5	0.5	0	53.3	54.6	0	153	156	0	29	29
2025	11	19	11	1	10	26.3	-0.9	0.977	0.4	0.3	0	53.8	54.6	0	153	156	0	28	29
2025	11	19	11	11	10	27.6	-1.6	0.977	0.5	0.4	0	53.8	54.6	0	153	156	0	28	29
2025	11	19	11	21	10	26.4	0.1	0.977	0.5	0.5	0	53.3	55.5	0	153	157	0	29	28
2025	11	19	11	31	10	26.7	-1.6	0.976	0.4	0.3	0	53.8	55	0	153	156	0	28	28
2025	11	19	11	41	10	26.9	-1.6	0.976	0.5	0.4	0	53.8	55	0	153	157	0	28	29
2025	11	19	11	51	10	26.5	0.4	0.976	0.5	0.5	0	53.8	55	0	153	157	0	28	29
2025	11	19	12	1	10	26.2	-1.2	0.976	0.5	0.5	0	53.8	54.6	0	153	156	0	28	29
2025	11	19	12	11	10	27.3	-1.2	0.975	0.6	0.5	0	53.8	54.6	0	153	156	0	28	29
2025	11	19	12	21	10	26.6	-0.1	0.975	0.4	0.3	0	53.8	55	0	153	157	0	28	29
2025	11	19	12	31	10	26.4	-1	0.974	0.4	0.3	0	53.8	54.6	0	153	156	0	28	29
2025	11	19	12	41	10	27	0	0.973	0.5	0.4	0	53.8	55	0	153	157	0	28	29
2025	11	19	12	51	10	25.8	0	0.972	0.4	0.3	0	53.8	55	0	153	157	0	28	29
2025	11	19	13	1	10	27.3	-1.6	0.971	0.5	0.5	0	53.3	54.6	0	153	156	0	29	29
2025	11	19	13	11	10	26.1	-1.2	0.971	0.5	0.4	0	53.3	54.6	0	153	156	0	29	29
2025	11	19	13	21	10	26.7	-1.3	0.97	0.5	0.4	0	53.8	54.6	0	153	156	0	28	29
2025	11	19	13	31	10	27	-1.3	0.97	0.4	0.3	0	53.8	55	0	153	156	0	28	28
2025	11	19	13	41	10	26.9	-0.4	0.97	0.5	0.5	0	53.3	54.6	0	153	156	0	29	29
2025	11	19	13	51	10	26.1	-0.8	0.969	0.5	0.4	0	53.3	54.6	0	152	156	0	28	29
2025	11	19	14	1	10	25.6	-0.4	0.969	0.4	0.3	0	54.2	55.5	0	154	157	0	28	28
2025	11	19	14	11	10	26.6	-0.9	0.969	0.5	0.4	0	53.3	54.6	0	153	156	0	29	29
2025	11	19	14	21	10	26.6	-1.2	0.969	0.3	0.2	0	53.3	55	0	152	156	0	28	28
2025	11	19	14	31	10	27.6	-1.2	0.969	0.4	0.3	0	53.3	54.2	0	152	155	0	28	29
2025	11	19	14	41	10	26.2	-0.3	0.969	0.3	0.2	0	53.3	54.2	0	152	155	0	28	29
2025	11	19	14	51	10	26.4	-0.5	0.969	0.4	0.3	0	54.2	54.6	0	153	156	0	27	29
2025	11	19	15	1	10	26.5	-1.1	0.969	0.5	0.4	0	53.3	54.2	0	152	155	0	28	29
2025	11	19	15	11	10	26	-0.6	0.968	0.4	0.3	0	53.8	54.6	0	153	156	0	28	29
2025	11	19	15	21	10	26.4	-1	0.968	0.5	0.4	0	52	54.6	0	150	155	0	29	28
2025	11	19	15	31	10	27.5	-1.9	0.968	0.5	0.4	0	53.3	54.6	0	153	155	0	29	28
2025	11	19	15	41	10	26.3	-1.2	0.968	0.5	0.4	0	53.8	54.6	0	153	155	0	28	28
2025	11	19	15	51	10	27.1	-1.5	0.968	0.5	0.5	0	53.8	55	0	153	156	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	19	16	1	10	26.7	-0.8	0.968	0.5	0.4	0	53.3	54.6	0	153	156	0	29	29
2025	11	19	16	11	10	26.7	-1.1	0.967	0.5	0.4	0	53.3	55	0	153	156	0	29	28
2025	11	19	16	21	10	26.5	-2.2	0.967	0.5	0.4	0	53.3	54.6	0	153	156	0	29	29
2025	11	19	16	31	10	26.8	-1.7	0.967	0.4	0.3	0	54.2	54.6	0	153	155	0	27	28
2025	11	19	16	41	10	25.4	-0.8	0.966	0.5	0.4	0	53.8	54.6	0	152	155	0	27	28
2025	11	19	16	51	10	26.4	-1.2	0.966	0.5	0.4	0	52.9	53.8	0	151	154	0	28	29
2025	11	19	17	1	10	27	-1.4	0.964	0.5	0.4	0	52	53.3	0	150	153	0	29	29
2025	11	19	17	11	10	26.6	-1.3	0.963	0.4	0.3	0	52.9	53.8	0	150	153	0	27	28
2025	11	19	17	21	10	26.4	-1.7	0.963	0.5	0.5	0	52.5	53.3	0	150	153	0	28	29
2025	11	19	17	31	10	27.3	-1	0.962	0.5	0.4	0	52.5	53.8	0	150	153	0	28	28
2025	11	19	17	41	10	26.8	-1.4	0.962	0.5	0.5	0	52.5	53.3	0	150	153	0	28	29
2025	11	19	17	51	10	26.5	-1.6	0.961	0.4	0.3	0	52.5	53.3	0	150	153	0	28	29
2025	11	19	18	1	10	27.3	-1.2	0.961	0.5	0.4	0	52.5	53.8	0	150	153	0	28	28
2025	11	19	18	11	10	26.6	-1.5	0.961	0.5	0.4	0	52.5	53.3	0	150	153	0	28	29
2025	11	19	18	21	10	26.5	-1.6	0.96	0.4	0.3	0	52.5	53.3	0	150	153	0	28	29
2025	11	19	18	31	10	26	-1.4	0.96	0.5	0.5	0	52.5	53.3	0	150	153	0	28	29
2025	11	19	18	41	10	25.2	-2.5	0.96	0.4	0.3	0	52.5	53.8	0	150	153	0	28	28
2025	11	19	18	51	10	27.4	-1.7	0.96	0.5	0.4	0	52.5	53.3	0	150	153	0	28	29
2025	11	19	19	1	10	25.8	-1.5	0.96	0.5	0.4	0	52.5	53.8	0	150	153	0	28	28
2025	11	19	19	11	10	26.8	-1.3	0.959	0.4	0.3	0	52.5	53.8	0	150	153	0	28	28
2025	11	19	19	21	10	26.8	-0.6	0.959	0.3	0.2	0	52.9	53.8	0	150	153	0	27	28
2025	11	19	19	31	10	27	-2.1	0.959	0.5	0.5	0	52	53.3	0	150	152	0	29	28
2025	11	19	19	41	10	25.8	-1.7	0.959	0.3	0.2	0	52.5	53.3	0	150	153	0	28	29
2025	11	19	19	51	10	26.1	-1	0.959	0.3	0.2	0	52	52.9	0	149	152	0	28	29
2025	11	19	20	1	10	26.2	-1.2	0.959	0.4	0.3	0	52	53.3	0	149	152	0	28	28
2025	11	19	20	11	10	25.7	-1.9	0.959	0.4	0.3	0	52	52.9	0	149	152	0	28	29
2025	11	19	20	21	10	26	-1.7	0.958	0.5	0.4	0	52	52.9	0	149	152	0	28	29
2025	11	19	20	31	10	26.4	-0.6	0.958	0.5	0.4	0	52.5	53.3	0	150	153	0	28	29
2025	11	19	20	41	10	26.1	-2.6	0.958	0.5	0.5	0	52	52.9	0	149	152	0	28	29
2025	11	19	20	51	10	26.5	-1.1	0.958	0.5	0.5	0	52	53.3	0	149	152	0	28	28
2025	11	19	21	1	10	26.5	-1.6	0.958	0.5	0.4	0	52	53.3	0	149	152	0	28	28
2025	11	19	21	11	10	26.5	-1.6	0.958	0.3	0.2	0	52	53.3	0	149	152	0	28	28
2025	11	19	21	21	10	25.5	-1.6	0.957	0.4	0.3	0	52	53.3	0	149	152	0	28	28
2025	11	19	21	31	10	26.5	-1.6	0.957	0.3	0.2	0	51.6	52.5	0	148	151	0	28	29
2025	11	19	21	41	10	26.2	-1.6	0.957	0.5	0.4	0	51.6	52.5	0	148	151	0	28	29
2025	11	19	21	51	10	25.1	-2.5	0.957	0.5	0.5	0	51.6	52.5	0	148	151	0	28	29
2025	11	19	22	1	10	27	-2	0.957	0.4	0.3	0	50.7	52.5	0	147	151	0	29	29
2025	11	19	22	11	10	26.8	-1.1	0.957	0.4	0.3	0	51.2	52.5	0	147	151	0	28	29
2025	11	19	22	21	10	26.2	-1.8	0.956	0.5	0.5	0	51.2	52	0	147	150	0	28	29
2025	11	19	22	31	10	25.7	-1.6	0.956	0.4	0.3	0	50.7	52	0	147	150	0	29	29
2025	11	19	22	41	10	25.9	-0.7	0.956	0.5	0.4	0	51.2	52	0	147	150	0	28	29
2025	11	19	22	51	10	25.7	-1.3	0.956	0.3	0.2	0	51.2	52.5	0	147	150	0	28	28
2025	11	19	23	1	10	26.7	-2.4	0.955	0.5	0.4	0	50.7	52	0	146	150	0	28	29
2025	11	19	23	11	10	26	-1.7	0.955	0.4	0.3	0	51.2	52.5	0	147	150	0	28	28
2025	11	19	23	21	10	25.7	-1.8	0.955	0.3	0.2	0	50.7	52	0	146	150	0	28	29
2025	11	19	23	31	10	25.8	-2.4	0.955	0.4	0.3	0	50.3	52	0	146	149	0	29	28
2025	11	19	23	41	10	25.7	-1.6	0.955	0.5	0.5	0	50.7	51.6	0	146	149	0	28	29
2025	11	19	23	51	10	26.5	-1.6	0.955	0.5	0.4	0	50.7	51.6	0	146	149	0	28	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	20	0	1	10	24.7	-3.6	0.954	0.5	0.4	0	51.2	52	0	147	150	0	28	29
2025	11	20	0	11	10	26.3	-1.6	0.954	0.5	0.4	0	51.2	52.5	0	147	150	0	28	28
2025	11	20	0	21	10	26.1	-1.6	0.954	0.5	0.4	0	51.2	52	0	147	150	0	28	29
2025	11	20	0	31	10	25.8	-2.9	0.954	0.4	0.3	0	51.2	52	0	147	150	0	28	29
2025	11	20	0	41	10	27.3	-2.3	0.954	0.5	0.4	0	50.7	52	0	147	149	0	29	28
2025	11	20	0	51	10	25.2	-1.8	0.953	0.5	0.4	0	50.7	51.6	0	146	149	0	28	29
2025	11	20	1	1	10	25.8	-1.4	0.953	0.5	0.5	0	50.3	51.6	0	146	149	0	29	29
2025	11	20	1	11	10	24.8	-1.2	0.953	0.4	0.3	0	50.7	51.6	0	146	149	0	28	29
2025	11	20	1	21	10	24.9	-1.8	0.953	0.5	0.4	0	50.3	51.6	0	146	149	0	29	29
2025	11	20	1	31	10	26.4	-1.3	0.953	0.5	0.4	0	50.3	52	0	145	149	0	28	28
2025	11	20	1	41	10	26.4	-2	0.953	0.5	0.4	0	50.3	51.6	0	145	149	0	28	29
2025	11	20	1	51	10	24.9	-1.2	0.952	0.4	0.3	0	50.7	51.6	0	146	149	0	28	29
2025	11	20	2	1	10	25.3	-1.4	0.952	0.5	0.4	0	50.3	51.2	0	145	148	0	28	29
2025	11	20	2	11	10	25.9	-0.8	0.952	0.3	0.2	0	50.3	51.6	0	146	149	0	29	29
2025	11	20	2	21	10	25.8	-0.9	0.951	0.5	0.5	0	50.3	51.2	0	145	148	0	28	29
2025	11	20	2	31	10	25.9	-2.1	0.951	0.4	0.3	0	50.3	51.6	0	145	148	0	28	28
2025	11	20	2	41	10	25.3	-1.7	0.95	0.5	0.4	0	50.3	51.2	0	145	148	0	28	29
2025	11	20	2	51	10	25.2	-1.6	0.95	0.5	0.4	0	49.9	52	0	145	149	0	29	28
2025	11	20	3	1	10	25.7	-2.4	0.949	0.4	0.3	0	50.3	51.2	0	145	148	0	28	29
2025	11	20	3	11	10	25.1	-1.4	0.948	0.4	0.3	0	50.3	51.2	0	145	148	0	28	29
2025	11	20	3	21	10	25.1	-2.1	0.948	0.5	0.5	0	49.9	51.2	0	144	148	0	28	29
2025	11	20	3	31	10	24.9	-1.3	0.948	0.5	0.4	0	49.9	51.6	0	145	148	0	29	28
2025	11	20	3	41	10	26.4	-1.6	0.947	0.5	0.5	0	49.9	51.2	0	144	148	0	28	29
2025	11	20	3	51	10	24.2	-1.4	0.947	0.5	0.5	0	50.3	51.2	0	145	148	0	28	29
2025	11	20	4	1	10	25.5	-1.7	0.947	0.5	0.4	0	49.9	51.2	0	144	148	0	28	29
2025	11	20	4	11	10	24.1	-1	0.947	0.5	0.4	0	49.9	51.2	0	144	148	0	28	29
2025	11	20	4	21	10	25.5	-1.6	0.947	0.5	0.4	0	49.9	50.7	0	144	147	0	28	29
2025	11	20	4	31	10	26.4	-1.4	0.947	0.5	0.4	0	49.9	50.7	0	144	147	0	28	29
2025	11	20	4	41	10	25.1	-2.5	0.946	0.5	0.4	0	49.5	50.7	0	144	147	0	29	29
2025	11	20	4	51	10	25.8	-2.5	0.946	0.5	0.5	0	50.3	51.2	0	145	148	0	28	29
2025	11	20	5	1	10	25.1	-2.1	0.946	0.5	0.4	0	49.9	50.7	0	144	147	0	28	29
2025	11	20	5	11	10	25.2	-2.3	0.946	0.4	0.3	0	49.9	51.2	0	145	147	0	29	28
2025	11	20	5	21	10	26.4	-2.3	0.946	0.5	0.4	0	49.9	50.7	0	144	147	0	28	29
2025	11	20	5	31	10	25.1	-2.4	0.946	0.5	0.5	0	49.9	50.7	0	144	147	0	28	29
2025	11	20	5	41	10	25.6	-2.4	0.946	0.5	0.5	0	49.9	50.7	0	144	147	0	28	29
2025	11	20	5	51	10	25.1	-1.3	0.946	0.5	0.4	0	49.9	50.7	0	144	147	0	28	29
2025	11	20	6	1	10	27.4	-1.6	0.946	0.3	0.2	0	49.9	51.2	0	144	147	0	28	28
2025	11	20	6	11	10	27	-2.1	0.946	0.5	0.4	0	49.9	50.7	0	144	147	0	28	29
2025	11	20	6	21	10	26.8	-1.2	0.946	0.5	0.4	0	49.5	50.7	0	144	147	0	29	29
2025	11	20	6	31	10	24.7	-1.5	0.945	0.4	0.3	0	49.5	50.7	0	144	147	0	29	29
2025	11	20	6	41	10	25.5	-2.1	0.945	0.4	0.3	0	49.5	50.7	0	144	147	0	29	29
2025	11	20	6	51	10	26.2	-1.2	0.945	0.5	0.4	0	49.5	50.7	0	144	147	0	29	29
2025	11	20	7	1	10	25.2	-2.6	0.945	0.5	0.5	0	49.9	50.7	0	144	147	0	28	29
2025	11	20	7	11	10	25.2	-0.7	0.945	0.5	0.4	0	49.9	50.7	0	144	147	0	28	29
2025	11	20	7	21	10	25.7	-1.5	0.945	0.4	0.3	0	49.5	50.7	0	144	147	0	29	29
2025	11	20	7	31	10	26.2	-1.5	0.945	0.5	0.5	0	49.9	50.3	0	144	146	0	28	29
2025	11	20	7	41	10	24.8	-0.8	0.945	0.4	0.3	0	49.9	51.2	0	144	147	0	28	28
2025	11	20	7	51	10	25.1	-1.1	0.945	0.5	0.4	0	49	50.3	0	143	146	0	29	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	20	8	1	10	25.2	-1.2	0.945	0.5	0.4	0	49	49.9	0	143	146	0	29	30
2025	11	20	8	11	10	25.2	-1.8	0.945	0.5	0.4	0	49.5	49.9	0	143	145	0	28	29
2025	11	20	8	21	10	24.5	-1.9	0.945	0.5	0.4	0	49	49.9	0	142	145	0	28	29
2025	11	20	8	31	10	26	-1.5	0.945	0.5	0.4	0	48.2	49.9	0	141	145	0	29	29
2025	11	20	8	41	10	25.1	-2	0.945	0.5	0.4	0	49	49.9	0	142	144	0	28	28
2025	11	20	8	51	10	24.5	-2.4	0.945	0.4	0.3	0	48.6	49.5	0	141	144	0	28	29
2025	11	20	9	1	10	25.5	-2.1	0.945	0.5	0.4	0	48.2	49.5	0	141	144	0	29	29
2025	11	20	9	11	10	25.6	-1.6	0.945	0.5	0.4	0	48.2	49	0	140	143	0	28	29
2025	11	20	9	21	10	24.9	-2	0.945	0.5	0.4	0	48.6	49.9	0	141	144	0	28	28
2025	11	20	9	31	10	26.2	-2	0.945	0.5	0.4	0	48.2	49.5	0	140	143	0	28	28
2025	11	20	9	41	10	25.4	-2.3	0.945	0.5	0.4	0	47.7	48.6	0	139	142	0	28	29
2025	11	20	9	51	10	25.7	-2.4	0.945	0.4	0.3	0	48.6	49.9	0	141	144	0	28	28
2025	11	20	10	1	10	24.7	-1.3	0.945	0.3	0.2	0	48.2	49	0	140	143	0	28	29
2025	11	20	10	11	10	25.6	-1.6	0.945	0.5	0.4	0	46.9	48.2	0	138	141	0	29	29
2025	11	20	10	21	10	25.6	-1.2	0.945	0.5	0.4	0	47.3	48.2	0	138	141	0	28	29
2025	11	20	10	31	10	26	-2	0.945	0.4	0.3	0	47.3	48.6	0	138	141	0	28	28
2025	11	20	10	41	10	25	-0.8	0.945	0.5	0.5	0	46.9	47.7	0	138	140	0	29	29
2025	11	20	10	51	10	25.7	-1.8	0.945	0.5	0.5	0	46.9	48.6	0	138	141	0	29	28
2025	11	20	11	1	10	25.9	-1.5	0.945	0.4	0.3	0	47.3	48.2	0	138	141	0	28	29
2025	11	20	11	11	10	26.9	-1.8	0.945	0.3	0.2	0	47.3	48.2	0	138	141	0	28	29
2025	11	20	11	21	10	25.4	-2	0.945	0.4	0.3	0	46.4	47.7	0	137	140	0	29	29
2025	11	20	11	31	10	24.8	-1.9	0.945	0.5	0.4	0	46.4	47.7	0	137	140	0	29	29
2025	11	20	11	41	10	25.4	-1.2	0.945	0.5	0.4	0	46.9	47.7	0	137	140	0	28	29
2025	11	20	11	51	10	25.7	-2.6	0.945	0.4	0.3	0	46.9	48.2	0	137	140	0	28	28
2025	11	20	12	1	10	26.2	-2	0.945	0.5	0.4	0	46.9	48.2	0	137	140	0	28	28
2025	11	20	12	11	10	25.3	-1.5	0.946	0.5	0.4	0	46.4	47.7	0	136	139	0	28	28
2025	11	20	12	21	10	25.7	-2	0.946	0.5	0.4	0	46.9	47.7	0	137	140	0	28	29
2025	11	20	12	31	10	24.9	-2.1	0.946	0.5	0.5	0	46.9	47.7	0	137	140	0	28	29
2025	11	20	12	41	10	24.7	-2.4	0.946	0.4	0.3	0	46.9	47.3	0	137	139	0	28	29
2025	11	20	12	51	10	25.6	-1	0.946	0.4	0.3	0	46.4	47.3	0	136	139	0	28	29
2025	11	20	13	1	10	26.1	-1.8	0.946	0.5	0.4	0	46.4	47.7	0	136	139	0	28	28
2025	11	20	13	11	10	25.6	-2.4	0.946	0.5	0.4	0	46.4	47.3	0	136	139	0	28	29
2025	11	20	13	21	10	25.7	-1.6	0.946	0.5	0.4	0	46.4	47.3	0	136	139	0	28	29
2025	11	20	13	31	10	26.3	-1.4	0.946	0.4	0.3	0	46.4	47.3	0	136	139	0	28	29
2025	11	20	13	41	10	25.7	-2.1	0.946	0.4	0.3	0	46.4	47.7	0	136	140	0	28	29
2025	11	20	13	51	10	25.8	-2.5	0.946	0.4	0.3	0	46.4	47.7	0	137	140	0	29	29
2025	11	20	14	1	10	25.6	-1.8	0.946	0.5	0.5	0	46.9	47.7	0	137	140	0	28	29
2025	11	20	14	11	10	25.2	-0.9	0.946	0.4	0.3	0	46.9	47.7	0	137	140	0	28	29
2025	11	20	14	21	10	26.6	-1.1	0.946	0.4	0.3	0	46.9	48.2	0	137	140	0	28	28
2025	11	20	14	31	10	25.3	-0.4	0.947	0.5	0.4	0	46.9	48.2	0	137	140	0	28	28
2025	11	20	14	41	10	24.1	-1.6	0.947	0.5	0.5	0	46.9	47.3	0	137	139	0	28	29
2025	11	20	14	51	10	25.5	-1.2	0.947	0.5	0.4	0	46.9	47.7	0	137	140	0	28	29
2025	11	20	15	1	10	26.3	-1.7	0.947	0.4	0.3	0	46.4	47.7	0	137	140	0	29	29
2025	11	20	15	11	10	25.5	-0.9	0.947	0.5	0.4	0	46.9	47.7	0	137	140	0	28	29
2025	11	20	15	21	10	25.2	-2.1	0.947	0.5	0.4	0	46.4	47.7	0	137	140	0	29	29
2025	11	20	15	31	10	26.3	-2.1	0.947	0.5	0.5	0	46.9	47.7	0	137	140	0	28	29
2025	11	20	15	41	10	25.9	-1.3	0.947	0.5	0.4	0	46.9	48.2	0	137	140	0	28	28
2025	11	20	15	51	10	25.4	-2	0.947	0.5	0.4	0	46.9	47.7	0	137	140	0	28	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	20	16	1	10	25.9	-1.5	0.947	0.4	0.3	0	48.2	48.6	0	140	142	0	28	29
2025	11	20	16	11	10	26.3	-1.1	0.947	0.4	0.3	0	48.2	49	0	140	143	0	28	29
2025	11	20	16	21	10	25.2	-2.4	0.947	0.5	0.4	0	50.7	51.2	0	146	148	0	28	29
2025	11	20	16	31	10	24.9	-0.8	0.948	0.3	0.2	0	51.2	52.5	0	147	150	0	28	28
2025	11	20	16	41	10	25.9	-1	0.948	0.5	0.4	0	52.5	53.8	0	151	154	0	29	29
2025	11	20	16	51	10	25.1	-1.5	0.948	0.5	0.4	0	53.3	53.8	0	152	154	0	28	29
2025	11	20	17	1	10	26	-1.4	0.949	0.4	0.3	0	52.9	53.8	0	151	154	0	28	29
2025	11	20	17	11	10	27.9	-1.1	0.949	0.4	0.3	0	52.5	53.3	0	150	153	0	28	29
2025	11	20	17	21	10	26.5	-1.2	0.949	0.5	0.4	0	52	53.3	0	149	152	0	28	28
2025	11	20	17	31	10	25	-1.3	0.949	0.5	0.4	0	51.2	52.9	0	148	151	0	29	28
2025	11	20	17	41	10	25.5	-0.8	0.95	0.4	0.3	0	51.2	52.5	0	147	150	0	28	28
2025	11	20	17	51	10	25.8	-0.4	0.95	0.3	0.2	0	50.7	51.6	0	146	149	0	28	29
2025	11	20	18	1	10	26.1	-0.8	0.95	0.4	0.3	0	50.7	51.2	0	146	148	0	28	29
2025	11	20	18	11	10	25.6	-1.5	0.95	0.5	0.4	0	50.3	51.6	0	145	149	0	28	29
2025	11	20	18	21	10	25.9	-1.2	0.95	0.5	0.5	0	49.9	51.6	0	145	148	0	29	28
2025	11	20	18	31	10	26.1	-0.2	0.95	0.5	0.5	0	50.3	51.2	0	145	148	0	28	29
2025	11	20	18	41	10	26	-1.6	0.95	0.5	0.4	0	49.9	51.2	0	145	148	0	29	29
2025	11	20	18	51	10	26.7	-1.6	0.95	0.3	0.2	0	50.3	51.2	0	145	148	0	28	29
2025	11	20	19	1	10	25	-1.6	0.951	0.5	0.4	0	49.9	51.2	0	144	147	0	28	28
2025	11	20	19	11	10	26	-2.4	0.95	0.5	0.4	0	49.5	50.7	0	143	146	0	28	28
2025	11	20	19	21	10	25.6	-1.5	0.95	0.5	0.4	0	49.5	51.2	0	143	147	0	28	28
2025	11	20	19	31	10	26	-1.9	0.95	0.5	0.4	0	49.5	50.3	0	143	146	0	28	29
2025	11	20	19	41	10	26.4	-2.3	0.95	0.5	0.5	0	49	50.3	0	142	145	0	28	28
2025	11	20	19	51	10	25.8	-1.5	0.95	0.5	0.4	0	49	50.3	0	142	145	0	28	28
2025	11	20	20	1	10	26.1	-1.5	0.95	0.5	0.4	0	49	49.9	0	142	145	0	28	29
2025	11	20	20	11	10	26.2	-0.9	0.951	0.5	0.4	0	49	49.9	0	142	145	0	28	29
2025	11	20	20	21	10	25.8	-1.8	0.95	0.5	0.4	0	48.6	50.3	0	142	145	0	29	28
2025	11	20	20	31	10	25.9	-1.5	0.95	0.5	0.4	0	48.6	49.5	0	141	144	0	28	29
2025	11	20	20	41	10	26.3	-1.4	0.95	0.4	0.3	0	48.6	49.5	0	141	144	0	28	29
2025	11	20	20	51	10	25.6	-1.5	0.95	0.5	0.4	0	48.2	49.9	0	141	144	0	29	28
2025	11	20	21	1	10	25.8	-1.6	0.95	0.5	0.4	0	48.6	49.5	0	141	144	0	28	29
2025	11	20	21	11	10	26.1	-1.3	0.949	0.5	0.5	0	48.6	49.9	0	141	144	0	28	28
2025	11	20	21	21	10	25.9	-1.5	0.949	0.5	0.4	0	47.7	49.5	0	140	144	0	29	29
2025	11	20	21	31	10	24.9	-1	0.949	0.5	0.5	0	48.6	49.5	0	141	144	0	28	29
2025	11	20	21	41	10	26.3	-2	0.949	0.5	0.4	0	48.2	49	0	140	143	0	28	29
2025	11	20	21	51	10	25.5	-2.4	0.949	0.5	0.4	0	47.7	49	0	140	143	0	29	29
2025	11	20	22	1	10	26.6	-0.8	0.948	0.5	0.4	0	48.2	49.5	0	140	143	0	28	28
2025	11	20	22	11	10	25.5	-2.4	0.948	0.5	0.4	0	48.2	49	0	140	143	0	28	29
2025	11	20	22	21	10	26.1	-0.8	0.948	0.5	0.4	0	48.2	49	0	140	143	0	28	29
2025	11	20	22	31	10	25.4	-1.5	0.948	0.5	0.4	0	48.2	49.5	0	140	143	0	28	28
2025	11	20	22	41	10	27.1	-1.7	0.948	0.5	0.5	0	48.2	49	0	140	143	0	28	29
2025	11	20	22	51	10	25.2	-1.9	0.948	0.5	0.5	0	48.2	49.5	0	140	143	0	28	28
2025	11	20	23	1	10	25.9	-1.8	0.948	0.5	0.5	0	48.2	49	0	140	143	0	28	29
2025	11	20	23	11	10	25.4	-2	0.948	0.5	0.5	0	47.7	49.5	0	139	143	0	28	28
2025	11	20	23	21	10	26.6	-3	0.948	0.5	0.4	0	48.2	49.5	0	139	143	0	27	28
2025	11	20	23	31	10	25.9	-2.3	0.948	0.5	0.5	0	47.7	49	0	140	143	0	29	29
2025	11	20	23	41	10	25.9	-1.8	0.948	0.5	0.4	0	48.2	49	0	140	143	0	28	29
2025	11	20	23	51	10	25.9	-1.6	0.947	0.4	0.3	0	47.7	49	0	139	142	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	21	0	1	10	25.1	-1.3	0.947	0.5	0.4	0	47.7	49.5	0	140	143	0	29	28
2025	11	21	0	11	10	25.5	-2.4	0.947	0.4	0.3	0	47.7	48.6	0	139	142	0	28	29
2025	11	21	0	21	10	25.9	-1.6	0.947	0.4	0.3	0	47.7	49	0	139	142	0	28	28
2025	11	21	0	31	10	25.1	-0.7	0.947	0.4	0.3	0	47.3	48.6	0	139	142	0	29	29
2025	11	21	0	41	10	26.4	-2	0.947	0.5	0.4	0	47.3	48.6	0	139	142	0	29	29
2025	11	21	0	51	10	24.5	-0.4	0.947	0.5	0.4	0	47.7	49	0	139	143	0	28	29
2025	11	21	1	1	10	24.8	-0.8	0.947	0.4	0.3	0	47.3	48.6	0	139	142	0	29	29
2025	11	21	1	11	10	25.4	-1.3	0.947	0.4	0.3	0	47.3	49	0	139	142	0	29	28
2025	11	21	1	21	10	26	-2.5	0.947	0.4	0.3	0	47.3	48.6	0	139	142	0	29	29
2025	11	21	1	31	10	25.6	-0.8	0.947	0.3	0.2	0	47.3	49	0	139	142	0	29	28
2025	11	21	1	41	10	25.5	-0.1	0.947	0.5	0.4	0	47.7	49	0	139	142	0	28	28
2025	11	21	1	51	10	25.3	-1.2	0.947	0.5	0.4	0	47.7	49	0	139	142	0	28	28
2025	11	21	2	1	10	24.4	-1.6	0.947	0.4	0.3	0	47.7	48.6	0	139	142	0	28	29
2025	11	21	2	11	10	25.9	-1.3	0.946	0.5	0.4	0	47.7	48.6	0	139	142	0	28	29
2025	11	21	2	21	10	26.1	-2	0.946	0.4	0.3	0	47.7	48.6	0	139	142	0	28	29
2025	11	21	2	31	10	25.4	-1.8	0.946	0.4	0.3	0	46.9	48.2	0	138	141	0	29	29
2025	11	21	2	41	10	25.2	-1.4	0.946	0.4	0.3	0	47.3	49	0	138	142	0	28	28
2025	11	21	2	51	10	25.4	-1.6	0.946	0.5	0.4	0	47.3	48.6	0	138	142	0	28	29
2025	11	21	3	1	10	26.3	-1.2	0.946	0.5	0.4	0	47.3	49	0	139	142	0	29	28
2025	11	21	3	11	10	25	-1.6	0.946	0.5	0.5	0	47.3	48.2	0	138	141	0	28	29
2025	11	21	3	21	10	24.8	-2.5	0.946	0.5	0.4	0	47.7	48.6	0	139	142	0	28	29
2025	11	21	3	31	10	25.1	-2.5	0.946	0.5	0.4	0	47.3	48.6	0	138	142	0	28	29
2025	11	21	3	41	10	26.3	-0.9	0.946	0.5	0.4	0	47.3	48.6	0	138	141	0	28	28
2025	11	21	3	51	10	24.6	-1.5	0.946	0.4	0.3	0	47.7	48.6	0	139	142	0	28	29
2025	11	21	4	1	10	25	-0.9	0.945	0.5	0.4	0	47.7	48.6	0	139	142	0	28	29
2025	11	21	4	11	10	25.6	-2	0.945	0.5	0.4	0	47.3	48.2	0	138	141	0	28	29
2025	11	21	4	21	10	26.9	-1.9	0.946	0.5	0.4	0	46.9	48.2	0	138	141	0	29	29
2025	11	21	4	31	10	25.1	-1	0.946	0.5	0.4	0	47.3	49	0	138	142	0	28	28
2025	11	21	4	41	10	24.6	-1.5	0.945	0.5	0.5	0	47.3	48.6	0	138	142	0	28	29
2025	11	21	4	51	10	24.8	-1.4	0.945	0.5	0.4	0	47.3	48.6	0	138	141	0	28	28
2025	11	21	5	1	10	25.5	-1.7	0.945	0.5	0.4	0	47.3	48.6	0	138	142	0	28	29
2025	11	21	5	11	10	24.8	-1.9	0.945	0.4	0.3	0	47.3	48.6	0	138	142	0	28	29
2025	11	21	5	21	10	26.3	-1.1	0.945	0.4	0.3	0	47.3	49	0	138	142	0	28	28
2025	11	21	5	31	10	25.7	-1.8	0.945	0.5	0.4	0	46.9	48.6	0	138	142	0	29	29
2025	11	21	5	41	10	26.1	-1.7	0.945	0.5	0.4	0	46.9	48.6	0	138	141	0	29	28
2025	11	21	5	51	10	26.1	-1.2	0.945	0.5	0.4	0	47.3	48.6	0	138	141	0	28	28
2025	11	21	6	1	10	25.1	-1.5	0.945	0.5	0.4	0	47.3	48.2	0	138	141	0	28	29
2025	11	21	6	11	10	24.9	-1.8	0.945	0.5	0.5	0	46.9	48.6	0	138	142	0	29	29
2025	11	21	6	21	10	25.7	-1.7	0.945	0.5	0.5	0	46.9	48.6	0	138	141	0	29	28
2025	11	21	6	31	10	26	-1.7	0.945	0.5	0.5	0	47.3	48.6	0	138	141	0	28	28
2025	11	21	6	41	10	25.3	-1.1	0.945	0.5	0.4	0	47.3	48.6	0	138	141	0	28	28
2025	11	21	6	51	10	25.2	-1.6	0.945	0.5	0.4	0	46.9	48.6	0	137	141	0	28	28
2025	11	21	7	1	10	25.5	-2.5	0.945	0.4	0.3	0	47.3	48.2	0	138	141	0	28	29
2025	11	21	7	11	10	25.9	-2.4	0.945	0.5	0.4	0	46.9	48.2	0	137	141	0	28	29
2025	11	21	7	21	10	24.8	-2.3	0.945	0.4	0.3	0	46.9	48.2	0	137	141	0	28	29
2025	11	21	7	31	10	25.3	-1.4	0.945	0.5	0.4	0	46.9	48.6	0	137	141	0	28	28
2025	11	21	7	41	10	24.8	-1	0.945	0.5	0.5	0	46.9	48.2	0	138	141	0	29	29
2025	11	21	7	51	10	24.1	-2	0.945	0.5	0.4	0	47.3	47.7	0	138	140	0	28	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	21	8	1	10	25.2	-0.4	0.945	0.5	0.4	0	46.4	47.7	0	137	140	0	29	29
2025	11	21	8	11	10	25.7	-2.9	0.945	0.5	0.4	0	46.9	47.7	0	137	140	0	28	29
2025	11	21	8	21	10	26.2	-2.1	0.945	0.4	0.3	0	46.4	47.3	0	136	139	0	28	29
2025	11	21	8	31	10	25.7	-1.8	0.945	0.5	0.5	0	46	46.9	0	135	138	0	28	29
2025	11	21	8	41	10	25.5	-1.9	0.944	0.4	0.3	0	46	46.9	0	135	138	0	28	29
2025	11	21	8	51	10	25.3	-1.3	0.945	0.5	0.4	0	45.6	46.4	0	134	137	0	28	29
2025	11	21	9	1	10	24.4	-1.4	0.945	0.5	0.4	0	45.6	46.4	0	134	137	0	28	29
2025	11	21	9	11	10	26	-2.7	0.945	0.5	0.4	0	45.6	46.4	0	134	137	0	28	29
2025	11	21	9	21	10	26	-0.8	0.944	0.4	0.3	0	45.2	46.4	0	134	137	0	29	29
2025	11	21	9	31	10	25.9	-1.8	0.945	0.5	0.4	0	45.2	46	0	133	136	0	28	29
2025	11	21	9	41	10	25.6	-2.1	0.945	0.5	0.4	0	45.2	46.4	0	133	136	0	28	28
2025	11	21	9	51	10	25.8	-1.6	0.945	0.5	0.5	0	44.7	46	0	133	135	0	29	28
2025	11	21	10	1	10	26	-1.2	0.945	0.5	0.4	0	44.3	46	0	132	136	0	29	29
2025	11	21	10	11	10	24	-0.8	0.945	0.5	0.5	0	44.7	46	0	132	136	0	28	29
2025	11	21	10	21	10	25.3	-2.1	0.945	0.5	0.4	0	44.7	45.6	0	132	135	0	28	29
2025	11	21	10	31	10	24.3	-1.6	0.944	0.5	0.4	0	45.2	46	0	133	136	0	28	29
2025	11	21	10	41	10	25.2	-2.8	0.945	0.5	0.5	0	44.7	46	0	133	136	0	29	29
2025	11	21	10	51	10	23.9	-1.4	0.944	0.5	0.4	0	44.7	46	0	133	136	0	29	29
2025	11	21	11	1	10	25.9	-1.5	0.945	0.5	0.5	0	44.7	46	0	132	136	0	28	29
2025	11	21	11	11	10	26.1	-1.2	0.945	0.5	0.4	0	44.7	46	0	132	135	0	28	28
2025	11	21	11	21	10	25	-1.1	0.945	0.4	0.3	0	44.3	46	0	131	135	0	28	28
2025	11	21	11	31	10	25.7	-1.6	0.945	0.5	0.4	0	44.3	45.2	0	131	134	0	28	29
2025	11	21	11	41	10	25.6	-2.3	0.945	0.5	0.5	0	44.3	45.2	0	131	134	0	28	29
2025	11	21	11	51	10	24.6	-1.5	0.945	0.4	0.3	0	44.3	46	0	131	135	0	28	28
2025	11	21	12	1	10	25.2	-1.1	0.945	0.5	0.4	0	44.7	46	0	132	136	0	28	29
2025	11	21	12	11	10	25.9	-1.8	0.945	0.5	0.4	0	44.7	46	0	132	136	0	28	29
2025	11	21	12	21	10	24.9	-1.6	0.945	0.5	0.4	0	44.7	46.4	0	132	136	0	28	28
2025	11	21	12	31	10	25.5	-0.6	0.945	0.4	0.3	0	44.3	45.6	0	132	135	0	29	29
2025	11	21	12	41	10	25.3	-1.2	0.945	0.5	0.5	0	44.3	46	0	132	136	0	29	29
2025	11	21	12	51	10	25.6	-2.4	0.945	0.4	0.3	0	44.3	45.6	0	131	135	0	28	29
2025	11	21	13	1	10	25.4	-2.8	0.945	0.5	0.4	0	44.3	45.2	0	131	134	0	28	29
2025	11	21	13	11	10	25.7	-1.1	0.945	0.4	0.3	0	44.3	46	0	131	135	0	28	28
2025	11	21	13	21	10	25.1	-1.6	0.945	0.5	0.4	0	45.2	46.4	0	133	137	0	28	29
2025	11	21	13	31	10	24.7	-0.9	0.945	0.4	0.3	0	44.7	46.4	0	132	136	0	28	28
2025	11	21	13	41	10	25.2	-0.8	0.945	0.4	0.3	0	44.7	46	0	132	135	0	28	28
2025	11	21	13	51	10	24.4	-1.1	0.945	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	21	14	1	10	25.4	-1.5	0.945	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	21	14	11	10	23.3	-1.7	0.945	0.4	0.3	0	45.2	46	0	133	136	0	28	29
2025	11	21	14	21	10	26.2	-2.1	0.945	0.5	0.5	0	46.4	47.7	0	136	140	0	28	29
2025	11	21	14	31	10	25.6	-2.4	0.945	0.5	0.4	0	45.6	46.9	0	134	137	0	28	28
2025	11	21	14	41	10	25.4	-1.6	0.945	0.4	0.3	0	45.6	47.3	0	135	139	0	29	29
2025	11	21	14	51	10	25.4	-1.6	0.945	0.5	0.4	0	46	47.3	0	135	139	0	28	29
2025	11	21	15	1	10	25.3	-2.1	0.945	0.4	0.3	0	45.6	46.9	0	134	138	0	28	29
2025	11	21	15	11	10	24.9	-0.8	0.945	0.5	0.5	0	46	46.9	0	135	138	0	28	29
2025	11	21	15	21	10	25.4	-2.9	0.945	0.5	0.4	0	46.4	47.7	0	136	140	0	28	29
2025	11	21	15	31	10	25.5	-2.5	0.945	0.3	0.2	0	46.9	49	0	138	142	0	29	28
2025	11	21	15	41	10	25.2	-1.9	0.945	0.5	0.4	0	45.6	47.7	0	135	139	0	29	28
2025	11	21	15	51	10	25	-2.2	0.945	0.5	0.4	0	46.4	47.7	0	137	140	0	29	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	21	16	1	10	25.8	-1.7	0.945	0.4	0.3	0	46.9	47.7	0	137	140	0	28	29
2025	11	21	16	11	10	24.8	-1.1	0.945	0.5	0.4	0	46	47.3	0	135	139	0	28	29
2025	11	21	16	21	10	25.3	-1.6	0.945	0.5	0.4	0	45.6	46.9	0	134	138	0	28	29
2025	11	21	16	31	10	25.3	-0.5	0.944	0.4	0.3	0	45.6	47.3	0	134	138	0	28	28
2025	11	21	16	41	10	26.1	-2	0.944	0.4	0.3	0	45.6	47.3	0	135	138	0	29	28
2025	11	21	16	51	10	24.5	-0.9	0.945	0.4	0.3	0	46	47.3	0	136	139	0	29	29
2025	11	21	17	1	10	26.2	-2.3	0.945	0.5	0.4	0	45.6	47.3	0	135	139	0	29	29
2025	11	21	17	11	10	25.3	-2.1	0.944	0.5	0.5	0	46.4	47.3	0	136	139	0	28	29
2025	11	21	17	21	10	25.3	-1	0.945	0.5	0.5	0	45.2	46.9	0	134	137	0	29	28
2025	11	21	17	31	10	24.8	-1.8	0.944	0.5	0.4	0	45.2	46.4	0	133	136	0	28	28
2025	11	21	17	41	10	25.1	-1.8	0.945	0.5	0.5	0	44.3	46	0	132	136	0	29	29
2025	11	21	17	51	10	26	-2.2	0.944	0.5	0.4	0	44.3	46	0	132	135	0	29	28
2025	11	21	18	1	10	24.9	-1.6	0.944	0.5	0.4	0	44.3	45.6	0	131	134	0	28	28
2025	11	21	18	11	10	25.6	-1.6	0.944	0.4	0.3	0	44.3	45.2	0	131	134	0	28	29
2025	11	21	18	21	10	25.2	-1.1	0.944	0.4	0.3	0	44.7	46	0	132	135	0	28	28
2025	11	21	18	31	10	25.4	-2.6	0.944	0.5	0.5	0	45.2	46.4	0	133	137	0	28	29
2025	11	21	18	41	10	25.9	-2.3	0.944	0.5	0.4	0	45.2	46.4	0	133	137	0	28	29
2025	11	21	18	51	10	25.2	-1.9	0.944	0.5	0.4	0	44.7	46.9	0	133	137	0	29	28
2025	11	21	19	1	10	25.3	-1.2	0.944	0.4	0.3	0	45.2	46.9	0	133	137	0	28	28
2025	11	21	19	11	10	25.2	-2.1	0.944	0.5	0.4	0	44.7	46	0	133	136	0	29	29
2025	11	21	19	21	10	25.1	-2.1	0.944	0.5	0.5	0	44.7	46.4	0	132	136	0	28	28
2025	11	21	19	31	10	26.1	-2	0.944	0.4	0.3	0	44.7	45.6	0	132	135	0	28	29
2025	11	21	19	41	10	25.4	-2	0.944	0.3	0.2	0	44.3	46	0	132	136	0	29	29
2025	11	21	19	51	10	25.8	-1.6	0.944	0.4	0.3	0	44.3	46	0	131	135	0	28	28
2025	11	21	20	1	10	24.8	-2.1	0.944	0.4	0.3	0	43.9	46	0	131	135	0	29	28
2025	11	21	20	11	10	24.4	-2	0.944	0.4	0.3	0	44.7	45.6	0	132	135	0	28	29
2025	11	21	20	21	10	24.4	-0.9	0.944	0.6	0.5	0	44.7	46	0	132	136	0	28	29
2025	11	21	20	31	10	25.5	-3	0.944	0.5	0.4	0	44.3	46	0	131	135	0	28	28
2025	11	21	20	41	10	24.8	-1.6	0.944	0.5	0.4	0	44.3	45.6	0	132	135	0	29	29
2025	11	21	20	51	10	25.1	-2.1	0.944	0.5	0.4	0	44.7	45.6	0	132	135	0	28	29
2025	11	21	21	1	10	25	-1.7	0.943	0.5	0.5	0	44.7	46.4	0	133	136	0	29	28
2025	11	21	21	11	10	25.4	-1.2	0.943	0.4	0.3	0	44.7	46	0	132	135	0	28	28
2025	11	21	21	21	10	24.8	-0.8	0.943	0.5	0.5	0	44.7	46	0	132	135	0	28	28
2025	11	21	21	31	10	26.2	-2.1	0.943	0.5	0.4	0	44.7	46	0	132	136	0	28	29
2025	11	21	21	41	10	24.8	-1.4	0.943	0.4	0.3	0	44.3	46	0	131	135	0	28	28
2025	11	21	21	51	10	25	-1.9	0.943	0.4	0.3	0	43.9	46	0	131	135	0	29	28
2025	11	21	22	1	10	25.2	-1	0.943	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	21	22	11	10	25.7	-2	0.943	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	21	22	21	10	26.8	-1.9	0.943	0.4	0.3	0	44.3	45.6	0	132	135	0	29	29
2025	11	21	22	31	10	24.8	-2.5	0.943	0.4	0.3	0	44.7	45.6	0	132	135	0	28	29
2025	11	21	22	41	10	25.6	-1.3	0.942	0.5	0.5	0	44.3	46	0	132	136	0	29	29
2025	11	21	22	51	10	24.6	-2.3	0.943	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	21	23	1	10	25.9	-2.8	0.943	0.4	0.3	0	44.3	45.6	0	132	135	0	29	29
2025	11	21	23	11	10	25.6	-1.9	0.942	0.5	0.4	0	43.9	45.6	0	131	135	0	29	29
2025	11	21	23	21	10	25	-1.2	0.942	0.5	0.4	0	43.9	45.6	0	131	135	0	29	29
2025	11	21	23	31	10	26	-1	0.942	0.4	0.3	0	44.3	46	0	131	135	0	28	28
2025	11	21	23	41	10	25.5	-1.9	0.942	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	21	23	51	10	24.7	-1.6	0.942	0.4	0.3	0	43.9	45.2	0	131	135	0	29	30

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	22	0	1	10	25.4	-2	0.942	0.4	0.3	0	44.3	45.6	0	131	134	0	28	28
2025	11	22	0	11	10	24.9	-2.3	0.942	0.4	0.3	0	44.3	45.6	0	131	135	0	28	29
2025	11	22	0	21	10	25.5	-2.7	0.942	0.4	0.3	0	43.9	45.6	0	131	135	0	29	29
2025	11	22	0	31	10	25.7	-1.8	0.942	0.5	0.4	0	44.7	45.6	0	132	135	0	28	29
2025	11	22	0	41	10	25.5	-2.1	0.942	0.5	0.4	0	44.3	45.6	0	131	134	0	28	28
2025	11	22	0	51	10	24.7	-2.8	0.941	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	22	1	1	10	24.2	-2.4	0.942	0.4	0.3	0	44.3	45.6	0	131	135	0	28	29
2025	11	22	1	11	10	25.5	-1.2	0.941	0.4	0.3	0	43.9	45.6	0	131	135	0	29	29
2025	11	22	1	21	10	25.6	-1.6	0.941	0.4	0.3	0	44.3	45.2	0	131	134	0	28	29
2025	11	22	1	31	10	25.6	-2.4	0.941	0.5	0.4	0	43.9	45.2	0	131	134	0	29	29
2025	11	22	1	41	10	25.4	-0.8	0.941	0.6	0.5	0	44.3	45.6	0	131	135	0	28	29
2025	11	22	1	51	10	25.7	-2.3	0.941	0.5	0.5	0	43.9	45.2	0	131	134	0	29	29
2025	11	22	2	1	10	24.9	-2.3	0.941	0.5	0.4	0	43.9	45.6	0	131	135	0	29	29
2025	11	22	2	11	10	25.1	-2.2	0.941	0.4	0.3	0	44.3	45.6	0	131	135	0	28	29
2025	11	22	2	21	10	24.9	-2.5	0.941	0.5	0.5	0	44.3	45.6	0	131	135	0	28	29
2025	11	22	2	31	10	26	-1.3	0.941	0.5	0.5	0	44.3	45.6	0	132	136	0	29	30
2025	11	22	2	41	10	24.2	-2.1	0.941	0.4	0.3	0	44.3	45.6	0	132	136	0	29	30
2025	11	22	2	51	10	24.3	-1.5	0.941	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	22	3	1	10	25.2	-2.6	0.94	0.4	0.3	0	44.3	45.6	0	131	135	0	28	29
2025	11	22	3	11	10	24.7	-1.9	0.94	0.5	0.4	0	45.2	46	0	132	135	0	27	28
2025	11	22	3	21	10	25.4	-2.6	0.94	0.5	0.4	0	43.9	45.6	0	131	135	0	29	29
2025	11	22	3	31	10	23.4	-2.5	0.94	0.5	0.4	0	44.3	46	0	132	136	0	29	29
2025	11	22	3	41	10	25.5	-1.4	0.94	0.5	0.4	0	44.7	45.6	0	132	135	0	28	29
2025	11	22	3	51	10	24.9	-1.8	0.94	0.3	0.2	0	44.3	46	0	132	135	0	29	28
2025	11	22	4	1	10	25	-1.6	0.939	0.5	0.4	0	44.7	45.6	0	132	135	0	28	29
2025	11	22	4	11	10	26	-2.1	0.94	0.4	0.3	0	44.7	45.6	0	132	135	0	28	29
2025	11	22	4	21	10	25	-2.1	0.939	0.4	0.3	0	44.3	46	0	131	135	0	28	28
2025	11	22	4	31	10	26.1	-2.2	0.939	0.5	0.5	0	44.7	45.6	0	132	135	0	28	29
2025	11	22	4	41	10	24.2	-3	0.938	0.5	0.4	0	44.7	45.6	0	132	135	0	28	29
2025	11	22	4	51	10	25.1	-2.2	0.938	0.5	0.4	0	44.7	45.6	0	132	135	0	28	29
2025	11	22	5	1	10	24.5	-1.6	0.937	0.5	0.4	0	44.7	45.6	0	132	135	0	28	29
2025	11	22	5	11	10	24.6	-1	0.937	0.5	0.4	0	45.2	46	0	132	136	0	27	29
2025	11	22	5	21	10	25.6	-1.3	0.938	0.5	0.4	0	44.7	46.4	0	133	137	0	29	29
2025	11	22	5	31	10	26	-2.4	0.938	0.5	0.4	0	44.7	46	0	132	136	0	28	29
2025	11	22	5	41	10	24.3	-2.1	0.937	0.3	0.2	0	44.7	46.4	0	132	136	0	28	28
2025	11	22	5	51	10	24.3	-2.5	0.937	0.3	0.2	0	44.7	46	0	132	136	0	28	29
2025	11	22	6	1	10	24.8	-2.5	0.937	0.5	0.4	0	44.7	46	0	132	136	0	28	29
2025	11	22	6	11	10	23.5	-1.7	0.938	0.4	0.3	0	44.7	46	0	132	136	0	28	29
2025	11	22	6	21	10	24.8	-1.1	0.937	0.3	0.2	0	44.7	46.4	0	132	136	0	28	28
2025	11	22	6	31	10	24.7	-1.5	0.936	0.5	0.4	0	45.2	46.4	0	133	136	0	28	28
2025	11	22	6	41	10	24.4	-2.1	0.936	0.5	0.4	0	44.7	46	0	132	136	0	28	29
2025	11	22	6	51	10	24.3	-0.9	0.936	0.5	0.5	0	45.2	46	0	132	136	0	27	29
2025	11	22	7	1	10	25	-2.9	0.936	0.5	0.4	0	44.3	46	0	132	136	0	29	29
2025	11	22	7	11	10	24.1	-1.6	0.937	0.4	0.3	0	44.3	46.4	0	132	136	0	29	28
2025	11	22	7	21	10	24.7	-2.1	0.937	0.4	0.3	0	44.7	46	0	132	136	0	28	29
2025	11	22	7	31	10	23.5	-1.2	0.936	0.5	0.4	0	44.7	46	0	132	136	0	28	29
2025	11	22	7	41	10	25.1	-2.5	0.936	0.5	0.4	0	46.4	47.7	0	136	140	0	28	29
2025	11	22	7	51	10	24.2	-1.4	0.935	0.4	0.3	0	45.2	46.9	0	133	138	0	28	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	22	8	1	10	25.4	-2	0.935	0.5	0.5	0	44.7	45.2	0	132	135	0	28	30
2025	11	22	8	11	10	25.4	-0.8	0.935	0.4	0.3	0	44.3	46	0	131	135	0	28	28
2025	11	22	8	21	10	26.1	-2.2	0.935	0.4	0.3	0	43.9	45.2	0	130	134	0	28	29
2025	11	22	8	31	10	24.2	-1.9	0.935	0.4	0.3	0	43.4	45.2	0	130	134	0	29	29
2025	11	22	8	41	10	25.2	-2.3	0.935	0.4	0.3	0	43.4	44.7	0	130	133	0	29	29
2025	11	22	8	51	10	25.4	-2	0.935	0.5	0.4	0	43.4	44.7	0	129	133	0	28	29
2025	11	22	9	1	10	24.1	-1.3	0.935	0.5	0.4	0	43	44.7	0	129	133	0	29	29
2025	11	22	9	11	10	24.5	-2.5	0.935	0.4	0.3	0	43	44.3	0	129	132	0	29	29
2025	11	22	9	21	10	24.7	-1.5	0.935	0.5	0.5	0	43.4	45.2	0	129	133	0	28	28
2025	11	22	9	31	10	24.5	-1.6	0.935	0.3	0.2	0	43	43.9	0	128	131	0	28	29
2025	11	22	9	41	10	25.7	-2.1	0.935	0.4	0.3	0	42.6	43.9	0	127	131	0	28	29
2025	11	22	9	51	10	25.2	-1.6	0.935	0.4	0.3	0	42.6	43.4	0	127	131	0	28	30
2025	11	22	10	1	10	23.8	-1.2	0.935	0.4	0.3	0	43	44.7	0	129	133	0	29	29
2025	11	22	10	11	10	24.5	-1.9	0.935	0.4	0.3	0	43	43.9	0	128	131	0	28	29
2025	11	22	10	21	10	25.6	-1.7	0.935	0.5	0.4	0	42.6	44.3	0	128	132	0	29	29
2025	11	22	10	31	10	25.4	-1.8	0.935	0.5	0.5	0	43	44.3	0	128	132	0	28	29
2025	11	22	10	41	10	24.7	-1.1	0.934	0.4	0.3	0	41.7	43.4	0	126	130	0	29	29
2025	11	22	10	51	10	24.6	-2	0.935	0.5	0.4	0	42.1	43	0	126	129	0	28	29
2025	11	22	11	1	10	23.7	-1.9	0.935	0.4	0.3	0	42.1	43.4	0	126	130	0	28	29
2025	11	22	11	11	10	23.7	-0.9	0.935	0.4	0.3	0	41.7	43.4	0	126	130	0	29	29
2025	11	22	11	21	10	25.1	-1.5	0.934	0.3	0.2	0	43	44.3	0	128	132	0	28	29
2025	11	22	11	31	10	23.9	-1.5	0.935	0.3	0.2	0	43.4	45.2	0	130	133	0	29	28
2025	11	22	11	41	10	24.3	-2.7	0.935	0.4	0.3	0	43.9	45.2	0	130	133	0	28	28
2025	11	22	11	51	10	26.2	-1.3	0.935	0.3	0.2	0	43.4	45.2	0	130	134	0	29	29
2025	11	22	12	1	10	25.3	-1.7	0.935	0.5	0.5	0	44.3	45.6	0	131	135	0	28	29
2025	11	22	12	11	10	24.5	-1.6	0.935	0.5	0.4	0	43.9	44.7	0	130	133	0	28	29
2025	11	22	12	21	10	25.3	-2.4	0.935	0.5	0.5	0	42.6	44.3	0	128	132	0	29	29
2025	11	22	12	31	10	25	-1.7	0.935	0.5	0.4	0	43.4	44.7	0	129	133	0	28	29
2025	11	22	12	41	10	24.8	-1.7	0.935	0.4	0.3	0	45.2	46	0	133	136	0	28	29
2025	11	22	12	51	10	24.5	-1.6	0.935	0.5	0.4	0	43.9	45.2	0	130	134	0	28	29
2025	11	22	13	1	10	24.3	-1.6	0.935	0.4	0.3	0	44.3	45.2	0	130	134	0	27	29
2025	11	22	13	11	10	25.7	-3.1	0.935	0.5	0.5	0	43.9	45.6	0	131	135	0	29	29
2025	11	22	13	21	10	25.4	-2.8	0.935	0.4	0.3	0	44.7	46.4	0	133	137	0	29	29
2025	11	22	13	31	10	26.5	-2.4	0.935	0.4	0.3	0	44.7	46.4	0	133	137	0	29	29
2025	11	22	13	41	10	24.7	-1.4	0.935	0.5	0.4	0	44.7	46	0	133	136	0	29	29
2025	11	22	13	51	10	25.2	-1.7	0.935	0.4	0.3	0	43	44.7	0	129	132	0	29	28
2025	11	22	14	1	10	25.5	-1.9	0.935	0.5	0.5	0	42.1	43.9	0	127	131	0	29	29
2025	11	22	14	11	10	24.8	-1.6	0.935	0.5	0.5	0	43	44.7	0	129	132	0	29	28
2025	11	22	14	21	10	25.7	-1.6	0.935	0.4	0.3	0	43.9	45.6	0	130	134	0	28	28
2025	11	22	14	31	10	24.1	-1.6	0.935	0.5	0.5	0	44.3	45.6	0	131	135	0	28	29
2025	11	22	14	41	10	26.8	-2.5	0.935	0.5	0.4	0	45.2	46	0	132	136	0	27	29
2025	11	22	14	51	10	24.6	-1.5	0.935	0.4	0.3	0	44.7	46.4	0	132	136	0	28	28
2025	11	22	15	1	10	25.4	-0.8	0.935	0.4	0.3	0	43.4	45.2	0	130	134	0	29	29
2025	11	22	15	11	10	24.2	-1.9	0.935	0.5	0.4	0	43.4	45.2	0	130	134	0	29	29
2025	11	22	15	21	10	24.4	-2.9	0.935	0.4	0.3	0	43.4	45.6	0	129	134	0	28	28
2025	11	22	15	31	10	25.4	-1.8	0.935	0.4	0.3	0	43.9	45.2	0	130	134	0	28	29
2025	11	22	15	41	10	24.7	-1.9	0.935	0.4	0.3	0	43.4	44.7	0	129	133	0	28	29
2025	11	22	15	51	10	25.1	-2.5	0.935	0.3	0.2	0	43	44.3	0	128	131	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	22	16	1	10	25.2	-1.1	0.935	0.4	0.3	0	42.6	43.9	0	127	131	0	28	29
2025	11	22	16	11	10	24.2	-1.2	0.935	0.5	0.5	0	42.6	44.3	0	127	131	0	28	28
2025	11	22	16	21	10	25	-2.1	0.935	0.4	0.3	0	43.4	45.6	0	130	134	0	29	28
2025	11	22	16	31	10	24.9	-1.9	0.935	0.5	0.5	0	43.9	44.7	0	129	133	0	27	29
2025	11	22	16	41	10	24.5	-2	0.935	0.4	0.3	0	43	44.3	0	128	132	0	28	29
2025	11	22	16	51	10	24.8	-1.6	0.935	0.4	0.3	0	42.1	44.3	0	127	131	0	29	28
2025	11	22	17	1	10	24.9	-2	0.935	0.5	0.4	0	43	44.3	0	128	132	0	28	29
2025	11	22	17	11	10	26.2	-1.2	0.935	0.4	0.3	0	43	44.3	0	128	132	0	28	29
2025	11	22	17	21	10	25.1	-1.5	0.935	0.4	0.3	0	43.4	44.7	0	129	133	0	28	29
2025	11	22	17	31	10	25.5	-1.6	0.935	0.5	0.4	0	43	44.7	0	129	133	0	29	29
2025	11	22	17	41	10	25.1	-2	0.935	0.4	0.3	0	43.4	45.6	0	129	134	0	28	28
2025	11	22	17	51	10	25	-1.2	0.935	0.4	0.3	0	43.4	44.7	0	129	133	0	28	29
2025	11	22	18	1	10	24.7	-2.7	0.935	0.5	0.4	0	43.9	44.7	0	130	133	0	28	29
2025	11	22	18	11	10	24.3	-1	0.935	0.5	0.4	0	43.9	45.2	0	130	134	0	28	29
2025	11	22	18	21	10	25.3	-2.9	0.935	0.4	0.3	0	43.9	45.2	0	130	134	0	28	29
2025	11	22	18	31	10	25.7	-1.6	0.935	0.3	0.2	0	44.3	46	0	131	135	0	28	28
2025	11	22	18	41	10	24	-2	0.935	0.4	0.3	0	44.7	45.6	0	131	135	0	27	29
2025	11	22	18	51	10	24.4	-1.9	0.935	0.4	0.3	0	43.4	45.2	0	130	134	0	29	29
2025	11	22	19	1	10	25.4	-1.3	0.935	0.5	0.4	0	43.4	45.2	0	130	134	0	29	29
2025	11	22	19	11	10	25.7	-2.2	0.935	0.5	0.4	0	43.9	45.6	0	130	134	0	28	28
2025	11	22	19	21	10	25.7	-2.2	0.935	0.4	0.3	0	43.4	45.6	0	130	134	0	29	28
2025	11	22	19	31	10	24.1	-2	0.935	0.5	0.5	0	43.9	45.2	0	130	134	0	28	29
2025	11	22	19	41	10	24.7	-1.4	0.935	0.5	0.4	0	43.4	45.6	0	130	135	0	29	29
2025	11	22	19	51	10	25.1	-1.5	0.935	0.5	0.5	0	43.9	45.2	0	130	134	0	28	29
2025	11	22	20	1	10	24.8	-1.8	0.935	0.5	0.4	0	44.3	46	0	131	135	0	28	28
2025	11	22	20	11	10	25.3	-1.2	0.935	0.5	0.5	0	44.3	45.6	0	131	135	0	28	29
2025	11	22	20	21	10	24.6	-2.8	0.935	0.4	0.3	0	43.4	45.6	0	130	135	0	29	29
2025	11	22	20	31	10	24.9	-1.3	0.935	0.4	0.3	0	43.9	45.6	0	130	134	0	28	28
2025	11	22	20	41	10	25.4	-2.3	0.935	0.4	0.3	0	44.3	45.6	0	131	134	0	28	28
2025	11	22	20	51	10	24.4	-2.4	0.935	0.4	0.3	0	43.9	45.2	0	130	134	0	28	29
2025	11	22	21	1	10	25.6	-1.8	0.935	0.5	0.4	0	43.9	45.2	0	130	134	0	28	29
2025	11	22	21	11	10	23.6	-1.3	0.935	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	22	21	21	10	24.4	-2.2	0.935	0.5	0.4	0	43.4	45.2	0	130	134	0	29	29
2025	11	22	21	31	10	24.2	-2.1	0.935	0.5	0.4	0	43.9	45.6	0	130	134	0	28	28
2025	11	22	21	41	10	25.4	-2.3	0.935	0.5	0.4	0	43.9	45.2	0	130	134	0	28	29
2025	11	22	21	51	10	23.8	-2.1	0.935	0.5	0.5	0	43.9	45.2	0	130	134	0	28	29
2025	11	22	22	1	10	25.9	-1.2	0.935	0.5	0.5	0	44.3	45.2	0	131	134	0	28	29
2025	11	22	22	11	10	25.7	-1.4	0.935	0.5	0.4	0	43.9	46	0	131	135	0	29	28
2025	11	22	22	21	10	24.9	-1.6	0.934	0.4	0.3	0	43.4	45.2	0	130	134	0	29	29
2025	11	22	22	31	10	24.6	-1.3	0.935	0.5	0.4	0	43.9	45.2	0	130	134	0	28	29
2025	11	22	22	41	10	24.9	-1.2	0.934	0.5	0.4	0	43.9	45.6	0	130	134	0	28	28
2025	11	22	22	51	10	25.2	-1.6	0.934	0.5	0.4	0	43.9	45.2	0	130	134	0	28	29
2025	11	22	23	1	10	26	-2	0.934	0.5	0.4	0	44.3	45.2	0	131	134	0	28	29
2025	11	22	23	11	10	23.9	-2.1	0.934	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	22	23	21	10	24.7	-2.7	0.934	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	22	23	31	10	25.7	-2.1	0.934	0.3	0.2	0	44.3	45.6	0	131	135	0	28	29
2025	11	22	23	41	10	24	-2.1	0.934	0.4	0.3	0	44.3	45.6	0	131	135	0	28	29
2025	11	22	23	51	10	25.3	-2.5	0.934	0.5	0.5	0	43.4	45.2	0	130	134	0	29	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	23	0	1	10	24.7	-2.7	0.934	0.5	0.4	0	43.9	45.2	0	131	134	0	29	29
2025	11	23	0	11	10	25.2	-1.6	0.934	0.5	0.4	0	44.3	46	0	131	135	0	28	28
2025	11	23	0	21	10	25.6	-2	0.934	0.4	0.3	0	44.3	46	0	131	135	0	28	28
2025	11	23	0	31	10	24.3	-2.6	0.934	0.5	0.5	0	44.3	45.6	0	131	135	0	28	29
2025	11	23	0	41	10	24.7	-1.7	0.934	0.4	0.3	0	43.9	45.6	0	131	135	0	29	29
2025	11	23	0	51	10	24.8	-1.7	0.934	0.3	0.2	0	44.7	46	0	132	136	0	28	29
2025	11	23	1	1	10	25.1	-1.1	0.934	0.4	0.3	0	44.3	45.6	0	131	135	0	28	29
2025	11	23	1	11	10	24.2	-1.6	0.934	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	23	1	21	10	25.2	-1.8	0.934	0.4	0.3	0	43.9	46	0	131	135	0	29	28
2025	11	23	1	31	10	24.1	-1.3	0.934	0.5	0.5	0	43.9	46	0	131	136	0	29	29
2025	11	23	1	41	10	24.4	-2.5	0.934	0.5	0.4	0	43.9	45.2	0	131	135	0	29	30
2025	11	23	1	51	10	24.5	-2.7	0.934	0.5	0.4	0	43.9	46.4	0	131	136	0	29	28
2025	11	23	2	1	10	26.2	-2.8	0.934	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	23	2	11	10	24.6	-1.2	0.934	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	23	2	21	10	24.8	-2.2	0.934	0.4	0.3	0	43.9	45.6	0	131	135	0	29	29
2025	11	23	2	31	10	25.8	-2.4	0.934	0.3	0.2	0	44.3	45.6	0	131	135	0	28	29
2025	11	23	2	41	10	24.3	-1.9	0.934	0.5	0.4	0	43.9	45.6	0	131	135	0	29	29
2025	11	23	2	51	10	24.8	-2.1	0.934	0.5	0.4	0	43.9	45.2	0	130	135	0	28	30
2025	11	23	3	1	10	24.3	-1.9	0.934	0.5	0.4	0	43.9	45.2	0	131	135	0	29	30
2025	11	23	3	11	10	25.2	-1.3	0.934	0.5	0.4	0	43.9	45.6	0	131	135	0	29	29
2025	11	23	3	21	10	24.6	-0.8	0.934	0.4	0.3	0	43.9	45.6	0	131	134	0	29	28
2025	11	23	3	31	10	24.1	-2.9	0.934	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	23	3	41	10	25.8	-2.3	0.933	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	23	3	51	10	23.8	-2.1	0.933	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	23	4	1	10	24.9	-2.1	0.933	0.3	0.2	0	43.9	46	0	130	135	0	28	28
2025	11	23	4	11	10	26.5	-1.9	0.933	0.4	0.3	0	43.9	45.6	0	130	134	0	28	28
2025	11	23	4	21	10	25.1	-2.1	0.933	0.4	0.3	0	43.4	45.6	0	130	134	0	29	28
2025	11	23	4	31	10	26.1	-2	0.933	0.5	0.4	0	43.4	45.2	0	130	134	0	29	29
2025	11	23	4	41	10	25.7	-2.8	0.933	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	23	4	51	10	26	-0.8	0.933	0.5	0.4	0	43.9	45.6	0	131	135	0	29	29
2025	11	23	5	1	10	25.4	-2.2	0.933	0.5	0.5	0	44.3	46	0	131	135	0	28	28
2025	11	23	5	11	10	24.5	-2	0.933	0.4	0.3	0	43.9	45.6	0	130	134	0	28	28
2025	11	23	5	21	10	25	-2.5	0.933	0.4	0.3	0	43.9	45.6	0	131	135	0	29	29
2025	11	23	5	31	10	24.6	-1.7	0.933	0.4	0.3	0	43.4	45.2	0	130	134	0	29	29
2025	11	23	5	41	10	24.7	-2.3	0.933	0.5	0.4	0	43.9	45.6	0	130	135	0	28	29
2025	11	23	5	51	10	25.1	-3.2	0.933	0.4	0.3	0	44.3	45.2	0	131	134	0	28	29
2025	11	23	6	1	10	25	-1.5	0.933	0.5	0.5	0	43.9	45.6	0	130	135	0	28	29
2025	11	23	6	11	10	24.4	-2.1	0.933	0.5	0.5	0	43.4	45.2	0	130	134	0	29	29
2025	11	23	6	21	10	24.9	-3	0.933	0.5	0.4	0	43.9	45.6	0	131	135	0	29	29
2025	11	23	6	31	10	24.1	-1.2	0.933	0.5	0.5	0	43.4	46	0	130	135	0	29	28
2025	11	23	6	41	10	24.4	-2.2	0.933	0.3	0.2	0	43.9	45.2	0	130	134	0	28	29
2025	11	23	6	51	10	24.9	-2.5	0.932	0.4	0.3	0	43.9	45.2	0	130	134	0	28	29
2025	11	23	7	1	10	25.2	-2.4	0.933	0.5	0.5	0	43.4	45.6	0	130	135	0	29	29
2025	11	23	7	11	10	24.8	-2.5	0.932	0.5	0.4	0	43.9	45.2	0	130	134	0	28	29
2025	11	23	7	21	10	24.5	-1.5	0.932	0.5	0.4	0	43.4	45.2	0	130	134	0	29	29
2025	11	23	7	31	10	25.1	-1.9	0.932	0.5	0.4	0	43.4	45.2	0	130	134	0	29	29
2025	11	23	7	41	10	24.5	-3.4	0.932	0.4	0.3	0	43.9	45.6	0	130	134	0	28	28
2025	11	23	7	51	10	24.3	-2.1	0.932	0.5	0.5	0	43.9	45.2	0	130	134	0	28	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	23	8	1	10	25.3	-1.5	0.932	0.5	0.5	0	43.4	45.2	0	130	134	0	29	29
2025	11	23	8	11	10	25.8	-2.1	0.932	0.5	0.4	0	43.4	44.7	0	130	133	0	29	29
2025	11	23	8	21	10	24.9	-2.1	0.932	0.4	0.3	0	43.9	44.7	0	130	133	0	28	29
2025	11	23	8	31	10	25.1	-2.4	0.932	0.4	0.3	0	43.4	44.7	0	130	134	0	29	30
2025	11	23	8	41	10	24.6	-1.2	0.932	0.5	0.5	0	43.4	45.2	0	130	134	0	29	29
2025	11	23	8	51	10	25.5	-2	0.932	0.4	0.3	0	43.4	45.2	0	130	134	0	29	29
2025	11	23	9	1	10	24	-2	0.932	0.5	0.4	0	43.4	45.2	0	130	134	0	29	29
2025	11	23	9	11	10	23.8	-1.1	0.932	0.5	0.5	0	43.9	45.2	0	131	134	0	29	29
2025	11	23	9	21	10	24.3	-1.6	0.932	0.5	0.5	0	43.9	45.2	0	131	135	0	29	30
2025	11	23	9	31	10	24.3	-1.1	0.932	0.5	0.4	0	43.9	45.6	0	131	134	0	29	28
2025	11	23	9	41	10	24.9	-1.6	0.932	0.5	0.4	0	44.3	45.2	0	131	135	0	28	30
2025	11	23	9	51	10	24.6	-2.4	0.932	0.5	0.5	0	43.9	45.6	0	131	135	0	29	29
2025	11	23	10	1	10	24.8	-1.5	0.932	0.5	0.5	0	43.9	45.6	0	131	135	0	29	29
2025	11	23	10	11	10	25.8	-2.6	0.932	0.4	0.3	0	43.9	45.6	0	131	135	0	29	29
2025	11	23	10	21	10	25.2	-2.5	0.932	0.5	0.5	0	44.3	45.6	0	131	135	0	28	29
2025	11	23	10	31	10	24.5	-1.6	0.932	0.4	0.3	0	43.9	44.7	0	130	134	0	28	30
2025	11	23	10	41	10	24.8	-1.8	0.932	0.4	0.3	0	43.9	45.6	0	131	135	0	29	29
2025	11	23	10	51	10	25.1	-2.4	0.932	0.5	0.4	0	43.9	45.2	0	131	135	0	29	30
2025	11	23	11	1	10	24.5	-1.3	0.932	0.5	0.4	0	43.9	45.2	0	130	134	0	28	29
2025	11	23	11	11	10	24.8	-2.4	0.932	0.4	0.3	0	43.4	45.2	0	130	134	0	29	29
2025	11	23	11	21	10	24.9	-0.7	0.932	0.4	0.3	0	44.3	45.6	0	131	134	0	28	28
2025	11	23	11	31	10	24	-1.6	0.932	0.4	0.3	0	43.9	45.6	0	131	135	0	29	29
2025	11	23	11	41	10	25.3	-1	0.932	0.5	0.5	0	43.9	45.6	0	131	135	0	29	29
2025	11	23	11	51	10	24.6	-2.1	0.932	0.5	0.4	0	43.4	45.2	0	130	134	0	29	29
2025	11	23	12	1	10	24.6	-3.2	0.932	0.5	0.5	0	43.4	45.2	0	130	134	0	29	29
2025	11	23	12	11	10	24.1	-2.9	0.932	0.4	0.3	0	44.3	45.2	0	130	134	0	27	29
2025	11	23	12	21	10	25	-1.3	0.932	0.5	0.4	0	45.2	46.4	0	133	137	0	28	29
2025	11	23	12	31	10	25.8	-2.4	0.932	0.5	0.4	0	44.7	46	0	132	136	0	28	29
2025	11	23	12	41	10	25.4	-2.1	0.932	0.4	0.3	0	44.7	46.4	0	133	137	0	29	29
2025	11	23	12	51	10	25	-2.6	0.932	0.5	0.4	0	44.7	46	0	132	136	0	28	29
2025	11	23	13	1	10	25.1	-2.4	0.932	0.5	0.4	0	43.4	44.7	0	130	133	0	29	29
2025	11	23	13	11	10	24.5	-1.9	0.932	0.4	0.3	0	43	44.3	0	128	132	0	28	29
2025	11	23	13	21	10	24.9	-2	0.932	0.5	0.4	0	43	45.2	0	129	133	0	29	28
2025	11	23	13	31	10	25.2	-2.1	0.932	0.4	0.3	0	43.4	45.2	0	130	134	0	29	29
2025	11	23	13	41	10	25.1	-2.4	0.932	0.5	0.4	0	43.9	45.2	0	130	134	0	28	29
2025	11	23	13	51	10	25.1	-2	0.932	0.5	0.4	0	44.7	45.6	0	132	135	0	28	29
2025	11	23	14	1	10	26.5	-2.4	0.933	0.5	0.4	0	43.9	45.2	0	130	134	0	28	29
2025	11	23	14	11	10	25.4	-2.6	0.933	0.5	0.4	0	43	43.9	0	128	131	0	28	29
2025	11	23	14	21	10	25.4	-2	0.933	0.5	0.5	0	42.6	43.9	0	127	131	0	28	29
2025	11	23	14	31	10	24.6	-1.6	0.933	0.5	0.4	0	42.6	44.3	0	127	131	0	28	28
2025	11	23	14	41	10	25.2	-1.2	0.933	0.4	0.3	0	43	44.7	0	129	133	0	29	29
2025	11	23	14	51	10	25.8	-1.9	0.933	0.4	0.3	0	43.9	45.2	0	131	134	0	29	29
2025	11	23	15	1	10	25.2	-2.4	0.933	0.4	0.3	0	43.9	45.2	0	130	134	0	28	29
2025	11	23	15	11	10	24.8	-2.1	0.933	0.5	0.4	0	43.9	44.7	0	130	133	0	28	29
2025	11	23	15	21	10	25.3	-2.7	0.933	0.3	0.2	0	43.4	44.7	0	129	133	0	28	29
2025	11	23	15	31	10	24.8	-1.5	0.933	0.4	0.3	0	43	44.7	0	128	132	0	28	28
2025	11	23	15	41	10	25.6	-2.5	0.933	0.5	0.4	0	42.6	43.9	0	127	131	0	28	29
2025	11	23	15	51	10	24.4	-1.8	0.933	0.3	0.2	0	43	43.9	0	128	131	0	28	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	23	16	1	10	24.2	-1.7	0.933	0.4	0.3	0	42.1	43.9	0	127	131	0	29	29
2025	11	23	16	11	10	24.7	-2.4	0.933	0.5	0.4	0	42.1	43.9	0	127	131	0	29	29
2025	11	23	16	21	10	25.4	-2.8	0.933	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	23	16	31	10	25.1	-1.8	0.933	0.4	0.3	0	42.1	43.4	0	126	130	0	28	29
2025	11	23	16	41	10	25.1	-2.1	0.933	0.5	0.5	0	42.1	43.9	0	127	131	0	29	29
2025	11	23	16	51	10	25.9	-1	0.933	0.5	0.4	0	43.4	45.2	0	129	133	0	28	28
2025	11	23	17	1	10	25.5	-1.2	0.933	0.4	0.3	0	43	44.7	0	128	132	0	28	28
2025	11	23	17	11	10	24	-2.5	0.933	0.4	0.3	0	43.4	44.7	0	129	132	0	28	28
2025	11	23	17	21	10	24.9	-2.1	0.933	0.3	0.2	0	43.4	44.7	0	130	133	0	29	29
2025	11	23	17	31	10	23.6	-1.6	0.933	0.5	0.4	0	43	45.2	0	129	133	0	29	28
2025	11	23	17	41	10	25.1	-2.1	0.933	0.5	0.4	0	43	44.3	0	128	132	0	28	29
2025	11	23	17	51	10	24.4	-2.5	0.933	0.4	0.3	0	42.6	44.3	0	128	131	0	29	28
2025	11	23	18	1	10	25.3	-2.1	0.933	0.5	0.4	0	43	44.3	0	128	132	0	28	29
2025	11	23	18	11	10	24	-2.4	0.933	0.4	0.3	0	43	43.9	0	128	131	0	28	29
2025	11	23	18	21	10	24.1	-1.8	0.933	0.5	0.4	0	43.4	44.7	0	129	132	0	28	28
2025	11	23	18	31	10	25.3	-2.4	0.933	0.3	0.2	0	43	44.7	0	128	132	0	28	28
2025	11	23	18	41	10	24.4	-2.1	0.933	0.5	0.5	0	43.4	44.3	0	129	132	0	28	29
2025	11	23	18	51	10	24.7	-2.4	0.933	0.4	0.3	0	43.4	44.7	0	129	133	0	28	29
2025	11	23	19	1	10	25.6	-2.7	0.933	0.4	0.3	0	43.4	45.2	0	130	134	0	29	29
2025	11	23	19	11	10	24.2	-1.7	0.933	0.5	0.4	0	43.4	44.7	0	130	133	0	29	29
2025	11	23	19	21	10	25.1	-1.5	0.933	0.4	0.3	0	43	45.2	0	129	133	0	29	28
2025	11	23	19	31	10	24.1	-2.5	0.933	0.5	0.5	0	43.4	45.2	0	129	133	0	28	28
2025	11	23	19	41	10	24.8	-2.5	0.933	0.5	0.4	0	43.4	45.2	0	130	133	0	29	28
2025	11	23	19	51	10	25.2	-1.3	0.933	0.5	0.4	0	43	44.7	0	129	133	0	29	29
2025	11	23	20	1	10	25.1	-1.6	0.933	0.5	0.4	0	43.9	45.2	0	130	134	0	28	29
2025	11	23	20	11	10	25.1	-2.3	0.933	0.5	0.4	0	44.7	45.6	0	132	135	0	28	29
2025	11	23	20	21	10	24.1	-2.5	0.933	0.4	0.3	0	44.3	46	0	132	136	0	29	29
2025	11	23	20	31	10	24.3	-2.5	0.933	0.5	0.4	0	43.9	45.2	0	130	134	0	28	29
2025	11	23	20	41	10	25.8	-2.2	0.933	0.4	0.3	0	43.4	45.2	0	129	133	0	28	28
2025	11	23	20	51	10	24.2	-2.1	0.933	0.4	0.3	0	43.9	45.2	0	130	134	0	28	29
2025	11	23	21	1	10	24.7	-3.1	0.932	0.5	0.5	0	43.4	44.7	0	129	133	0	28	29
2025	11	23	21	11	10	24.5	-1.7	0.932	0.4	0.3	0	43.9	45.2	0	130	134	0	28	29
2025	11	23	21	21	10	24.7	-1.3	0.932	0.4	0.3	0	43.9	45.2	0	130	134	0	28	29
2025	11	23	21	31	10	24.4	-2	0.932	0.5	0.4	0	43.4	44.7	0	130	133	0	29	29
2025	11	23	21	41	10	25.6	-1.6	0.932	0.5	0.4	0	43.9	45.2	0	130	134	0	28	29
2025	11	23	21	51	10	24.2	-1.9	0.932	0.5	0.4	0	44.7	45.2	0	131	134	0	27	29
2025	11	23	22	1	10	25	-1.4	0.932	0.3	0.2	0	43.9	46	0	131	135	0	29	28
2025	11	23	22	11	10	24.2	-1.2	0.932	0.3	0.2	0	44.3	45.6	0	131	135	0	28	29
2025	11	23	22	21	10	24.6	-1.8	0.932	0.5	0.5	0	44.3	45.6	0	131	135	0	28	29
2025	11	23	22	31	10	25.3	-1.4	0.932	0.5	0.5	0	44.7	46	0	132	136	0	28	29
2025	11	23	22	41	10	24.6	-2.3	0.932	0.4	0.3	0	44.7	46	0	132	136	0	28	29
2025	11	23	22	51	10	24.6	-2.3	0.932	0.3	0.2	0	44.3	46	0	132	136	0	29	29
2025	11	23	23	1	10	25	-2.4	0.932	0.5	0.4	0	44.7	45.6	0	132	135	0	28	29
2025	11	23	23	11	10	25	-2	0.932	0.5	0.4	0	44.7	45.6	0	132	135	0	28	29
2025	11	23	23	21	10	25.2	-2.4	0.932	0.5	0.4	0	44.3	46.4	0	132	136	0	29	28
2025	11	23	23	31	10	25.1	-2.1	0.932	0.5	0.4	0	44.7	46.4	0	132	136	0	28	28
2025	11	23	23	41	10	24.1	-2.7	0.932	0.5	0.5	0	44.3	46.4	0	132	136	0	29	28
2025	11	23	23	51	10	25.1	-2.1	0.932	0.5	0.4	0	44.7	46	0	132	136	0	28	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	24	0	1	10	24.4	-2.6	0.932	0.5	0.4	0	44.7	46	0	133	136	0	29	29
2025	11	24	0	11	10	25	-1.6	0.931	0.5	0.4	0	44.7	46	0	133	136	0	29	29
2025	11	24	0	21	10	25.1	-1.9	0.931	0.4	0.3	0	44.7	46.4	0	132	136	0	28	28
2025	11	24	0	31	10	24.6	-2.4	0.932	0.3	0.2	0	44.7	46	0	132	136	0	28	29
2025	11	24	0	41	10	25.3	-0.7	0.931	0.5	0.4	0	44.3	46	0	132	136	0	29	29
2025	11	24	0	51	10	23.7	-2.1	0.931	0.5	0.4	0	44.3	46	0	132	136	0	29	29
2025	11	24	1	1	10	26.1	-1.9	0.931	0.3	0.2	0	44.7	45.6	0	132	135	0	28	29
2025	11	24	1	11	10	24.4	-2.3	0.931	0.5	0.4	0	44.7	45.6	0	132	135	0	28	29
2025	11	24	1	21	10	25.1	-2.2	0.931	0.4	0.3	0	44.3	45.6	0	131	135	0	28	29
2025	11	24	1	31	10	24.9	-2.5	0.931	0.3	0.2	0	44.7	45.6	0	132	135	0	28	29
2025	11	24	1	41	10	25	-2.1	0.931	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	24	1	51	10	24.4	-2.9	0.931	0.3	0.2	0	43.4	45.6	0	130	135	0	29	29
2025	11	24	2	1	10	24.9	-2.4	0.931	0.5	0.4	0	43.9	45.6	0	131	135	0	29	29
2025	11	24	2	11	10	26	-2.4	0.931	0.5	0.5	0	43.9	45.6	0	131	135	0	29	29
2025	11	24	2	21	10	25.2	-2	0.931	0.3	0.2	0	44.3	45.6	0	131	135	0	28	29
2025	11	24	2	31	10	25.1	-2.2	0.931	0.5	0.5	0	43.9	45.2	0	131	134	0	29	29
2025	11	24	2	41	10	25.8	-2.1	0.931	0.5	0.5	0	43.9	45.2	0	131	134	0	29	29
2025	11	24	2	51	10	25.6	-1.6	0.931	0.5	0.4	0	43.4	45.2	0	130	134	0	29	29
2025	11	24	3	1	10	25.2	-2.3	0.931	0.5	0.5	0	43.9	45.2	0	130	134	0	28	29
2025	11	24	3	11	10	25.4	-2.8	0.931	0.5	0.4	0	43.4	45.2	0	130	134	0	29	29
2025	11	24	3	21	10	23.9	-2.2	0.931	0.5	0.4	0	43.4	45.6	0	130	134	0	29	28
2025	11	24	3	31	10	25.1	-1.6	0.931	0.5	0.4	0	43.9	45.2	0	130	134	0	28	29
2025	11	24	3	41	10	25.1	-2.3	0.931	0.5	0.4	0	43.9	44.7	0	130	133	0	28	29
2025	11	24	3	51	10	25.3	-2.3	0.931	0.3	0.2	0	43.9	45.2	0	130	134	0	28	29
2025	11	24	4	1	10	25.5	-1.2	0.931	0.5	0.4	0	43.4	45.6	0	130	134	0	29	28
2025	11	24	4	11	10	25.2	-3	0.931	0.5	0.4	0	43.4	44.7	0	130	133	0	29	29
2025	11	24	4	21	10	24.5	-1.5	0.931	0.4	0.3	0	43.4	44.7	0	130	133	0	29	29
2025	11	24	4	31	10	24.3	-1.9	0.931	0.5	0.4	0	43.9	45.2	0	130	134	0	28	29
2025	11	24	4	41	10	25	-2.8	0.931	0.4	0.3	0	43.4	45.2	0	130	134	0	29	29
2025	11	24	4	51	10	24.6	-2	0.931	0.5	0.4	0	43.4	45.2	0	130	134	0	29	29
2025	11	24	5	1	10	25.4	-1.6	0.93	0.4	0.3	0	43.4	45.6	0	130	134	0	29	28
2025	11	24	5	11	10	24.7	-2.7	0.93	0.5	0.4	0	43.4	45.2	0	130	134	0	29	29
2025	11	24	5	21	10	24.7	-2.8	0.93	0.5	0.4	0	43.4	45.2	0	130	134	0	29	29
2025	11	24	5	31	10	23.4	-2.1	0.93	0.4	0.3	0	43.9	44.7	0	130	133	0	28	29
2025	11	24	5	41	10	24.6	-1.5	0.93	0.4	0.3	0	43.4	45.2	0	130	133	0	29	28
2025	11	24	5	51	10	23.6	-1.4	0.93	0.5	0.4	0	43.4	45.2	0	130	134	0	29	29
2025	11	24	6	1	10	24.9	-2.2	0.93	0.4	0.3	0	43	44.7	0	129	133	0	29	29
2025	11	24	6	11	10	24.6	-2	0.93	0.4	0.3	0	43.4	44.7	0	129	133	0	28	29
2025	11	24	6	21	10	24.4	-2.4	0.93	0.5	0.4	0	43.4	44.7	0	130	133	0	29	29
2025	11	24	6	31	10	25.2	-2.8	0.93	0.4	0.3	0	43	44.7	0	129	133	0	29	29
2025	11	24	6	41	10	25.2	-2.5	0.93	0.5	0.4	0	43.4	44.7	0	129	133	0	28	29
2025	11	24	6	51	10	24.6	-1.8	0.93	0.5	0.4	0	43	44.3	0	129	133	0	29	30
2025	11	24	7	1	10	24.9	-2.2	0.93	0.5	0.4	0	43	44.3	0	129	133	0	29	30
2025	11	24	7	11	10	25.8	-1.5	0.93	0.5	0.5	0	43	44.7	0	129	133	0	29	29
2025	11	24	7	21	10	25.2	-1.2	0.93	0.4	0.3	0	43	44.7	0	129	133	0	29	29
2025	11	24	7	31	10	25.8	-0.8	0.93	0.3	0.2	0	43.4	44.7	0	130	133	0	29	29
2025	11	24	7	41	10	24.5	-2.2	0.93	0.5	0.4	0	43	44.7	0	129	133	0	29	29
2025	11	24	7	51	10	23.2	-2.1	0.93	0.4	0.3	0	43	44.7	0	129	133	0	29	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	24	8	1	10	24.7	-2.7	0.93	0.5	0.4	0	43	44.7	0	129	133	0	29	29
2025	11	24	8	11	10	24.7	-2.2	0.93	0.5	0.4	0	43	44.7	0	129	133	0	29	29
2025	11	24	8	21	10	24.9	-1.7	0.93	0.4	0.3	0	43.4	44.7	0	129	133	0	28	29
2025	11	24	8	31	10	24.7	-2.4	0.93	0.5	0.4	0	43	44.7	0	129	133	0	29	29
2025	11	24	8	41	10	25.3	-2.5	0.93	0.5	0.4	0	43.4	44.7	0	130	133	0	29	29
2025	11	24	8	51	10	24.4	-1.7	0.93	0.5	0.4	0	43	44.7	0	129	133	0	29	29
2025	11	24	9	1	10	24.5	-0.8	0.93	0.4	0.3	0	43	44.3	0	129	132	0	29	29
2025	11	24	9	11	10	25.3	-2.3	0.93	0.5	0.4	0	42.6	44.3	0	128	132	0	29	29
2025	11	24	9	21	10	23.8	-2	0.929	0.4	0.3	0	43	43.9	0	128	131	0	28	29
2025	11	24	9	31	10	24.4	-2.2	0.93	0.4	0.3	0	42.6	44.3	0	128	132	0	29	29
2025	11	24	9	41	10	25.4	-1.9	0.93	0.3	0.2	0	42.1	43.9	0	127	131	0	29	29
2025	11	24	9	51	10	23.6	-2	0.929	0.5	0.4	0	43.4	44.3	0	129	132	0	28	29
2025	11	24	10	1	10	24.9	-1.9	0.93	0.3	0.2	0	42.6	43.9	0	127	131	0	28	29
2025	11	24	10	11	10	24.3	-3.1	0.93	0.4	0.3	0	42.6	43.9	0	127	131	0	28	29
2025	11	24	10	21	10	24.4	-3	0.93	0.5	0.5	0	42.1	43.9	0	127	131	0	29	29
2025	11	24	10	31	10	24.2	-3	0.93	0.5	0.5	0	42.6	43.9	0	127	131	0	28	29
2025	11	24	10	41	10	25	-2	0.93	0.5	0.4	0	42.6	43	0	127	130	0	28	30
2025	11	24	10	51	10	25	-1.5	0.93	0.4	0.3	0	41.7	43.4	0	126	130	0	29	29
2025	11	24	11	1	10	25.1	-2.3	0.93	0.4	0.3	0	42.1	43.4	0	126	130	0	28	29
2025	11	24	11	11	10	24.3	-0.8	0.93	0.5	0.4	0	42.1	44.3	0	127	132	0	29	29
2025	11	24	11	21	10	24.4	-1.9	0.93	0.5	0.4	0	42.1	43.9	0	127	131	0	29	29
2025	11	24	11	31	10	22.7	-1.8	0.93	0.5	0.4	0	42.6	43.9	0	127	131	0	28	29
2025	11	24	11	41	10	24.3	-1.1	0.93	0.5	0.4	0	42.1	43.4	0	127	130	0	29	29
2025	11	24	11	51	10	23.6	-1.4	0.93	0.4	0.3	0	41.7	43.4	0	126	130	0	29	29
2025	11	24	12	1	10	25.2	-1.6	0.93	0.5	0.4	0	42.6	43.4	0	127	130	0	28	29
2025	11	24	12	11	10	23.8	-1.1	0.93	0.5	0.5	0	41.7	43.4	0	126	130	0	29	29
2025	11	24	12	21	10	23.6	-1.6	0.93	0.5	0.4	0	42.1	43	0	126	129	0	28	29
2025	11	24	12	31	10	24.1	-1.4	0.93	0.4	0.3	0	41.3	43	0	125	129	0	29	29
2025	11	24	12	41	10	24.5	-2	0.93	0.5	0.4	0	41.3	43	0	125	129	0	29	29
2025	11	24	12	51	10	24	-1.4	0.931	0.4	0.3	0	41.3	43.4	0	125	129	0	29	28
2025	11	24	13	1	10	24.3	-1.7	0.931	0.5	0.4	0	41.3	43	0	125	129	0	29	29
2025	11	24	13	11	10	24.7	-2.6	0.931	0.5	0.4	0	41.3	43	0	125	129	0	29	29
2025	11	24	13	21	10	25.2	-1.5	0.931	0.5	0.5	0	42.1	43.4	0	126	130	0	28	29
2025	11	24	13	31	10	25.2	-2.1	0.931	0.5	0.5	0	41.7	43.4	0	126	130	0	29	29
2025	11	24	13	41	10	25.2	-2.6	0.931	0.4	0.3	0	42.1	43	0	126	129	0	28	29
2025	11	24	13	51	10	24.6	-2.8	0.931	0.5	0.4	0	41.7	43	0	125	129	0	28	29
2025	11	24	14	1	10	25.1	-1.7	0.931	0.5	0.4	0	42.1	43	0	126	129	0	28	29
2025	11	24	14	11	10	24.5	-2.4	0.931	0.5	0.4	0	42.1	43.4	0	126	130	0	28	29
2025	11	24	14	21	10	23.9	-1.5	0.931	0.4	0.3	0	41.7	43.4	0	126	130	0	29	29
2025	11	24	14	31	10	24.7	-1.5	0.931	0.6	0.5	0	42.6	43.9	0	127	131	0	28	29
2025	11	24	14	41	10	24.4	-1.8	0.932	0.4	0.3	0	42.1	43.9	0	127	131	0	29	29
2025	11	24	14	51	10	24.7	-0.8	0.932	0.4	0.3	0	42.6	44.3	0	127	131	0	28	28
2025	11	24	15	1	10	25.7	-2.1	0.932	0.5	0.4	0	43	43.9	0	128	131	0	28	29
2025	11	24	15	11	10	24.8	-1.4	0.932	0.3	0.2	0	42.1	43.9	0	127	131	0	29	29
2025	11	24	15	21	10	25.1	-1.9	0.932	0.4	0.3	0	42.1	43.9	0	127	131	0	29	29
2025	11	24	15	31	10	23.8	-2.2	0.932	0.6	0.5	0	42.6	43.9	0	127	131	0	28	29
2025	11	24	15	41	10	26.1	-2.2	0.932	0.5	0.4	0	42.6	43.9	0	127	131	0	28	29
2025	11	24	15	51	10	24.9	-2.3	0.932	0.5	0.4	0	42.1	43.4	0	127	130	0	29	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	24	16	1	10	25.3	-2.5	0.932	0.5	0.4	0	42.1	43.4	0	127	130	0	29	29
2025	11	24	16	11	10	24.7	-2.9	0.932	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	24	16	21	10	24.9	-1.6	0.932	0.4	0.3	0	41.7	43	0	126	129	0	29	29
2025	11	24	16	31	10	24.3	-3.2	0.932	0.5	0.5	0	41.7	43	0	125	129	0	28	29
2025	11	24	16	41	10	25.3	-2.2	0.932	0.5	0.4	0	41.3	43	0	125	129	0	29	29
2025	11	24	16	51	10	24.6	-1.5	0.932	0.5	0.5	0	41.7	43	0	125	129	0	28	29
2025	11	24	17	1	10	24.3	-1.3	0.932	0.5	0.4	0	42.1	43	0	126	129	0	28	29
2025	11	24	17	11	10	24.8	-1.1	0.932	0.5	0.4	0	42.1	43	0	126	129	0	28	29
2025	11	24	17	21	10	23.8	-2.3	0.932	0.5	0.4	0	42.1	44.3	0	127	132	0	29	29
2025	11	24	17	31	10	24.4	-2.3	0.932	0.5	0.4	0	42.6	43.9	0	127	131	0	28	29
2025	11	24	17	41	10	24.7	-1.4	0.932	0.5	0.4	0	42.6	44.3	0	127	131	0	28	28
2025	11	24	17	51	10	24.7	-2.7	0.932	0.4	0.3	0	42.6	43.4	0	127	130	0	28	29
2025	11	24	18	1	10	24.4	-1.3	0.932	0.4	0.3	0	42.1	43.9	0	127	130	0	29	28
2025	11	24	18	11	10	24.6	-2.1	0.932	0.5	0.5	0	42.6	44.3	0	127	131	0	28	28
2025	11	24	18	21	10	24.9	-1.3	0.932	0.4	0.3	0	42.6	43.9	0	127	130	0	28	28
2025	11	24	18	31	10	25.8	-1.4	0.932	0.5	0.4	0	42.6	43.9	0	128	131	0	29	29
2025	11	24	18	41	10	24.7	-2.6	0.932	0.5	0.4	0	43	43.9	0	128	131	0	28	29
2025	11	24	18	51	10	25.6	-1.7	0.932	0.5	0.4	0	42.6	43.9	0	128	131	0	29	29
2025	11	24	19	1	10	24.7	-2.2	0.932	0.5	0.4	0	43	44.3	0	128	132	0	28	29
2025	11	24	19	11	10	25.8	-1.6	0.932	0.5	0.4	0	43	44.7	0	128	132	0	28	28
2025	11	24	19	21	10	23.7	-2.5	0.932	0.5	0.4	0	42.6	44.3	0	128	132	0	29	29
2025	11	24	19	31	10	24.7	-2.2	0.932	0.3	0.2	0	43	44.3	0	128	132	0	28	29
2025	11	24	19	41	10	24.5	-2.9	0.932	0.4	0.3	0	42.6	44.3	0	128	132	0	29	29
2025	11	24	19	51	10	24.3	-2.6	0.932	0.4	0.3	0	43	44.7	0	128	132	0	28	28
2025	11	24	20	1	10	24.7	-2	0.932	0.5	0.5	0	42.6	44.3	0	128	132	0	29	29
2025	11	24	20	11	10	25	-2.4	0.932	0.5	0.4	0	43	43.9	0	128	131	0	28	29
2025	11	24	20	21	10	24.8	-3.3	0.932	0.5	0.4	0	42.6	43.9	0	127	131	0	28	29
2025	11	24	20	31	10	24.3	-2.7	0.932	0.5	0.4	0	42.6	43.9	0	127	131	0	28	29
2025	11	24	20	41	10	24.5	-1.6	0.932	0.4	0.3	0	42.6	44.3	0	128	132	0	29	29
2025	11	24	20	51	10	25.6	-2.7	0.932	0.5	0.4	0	42.6	44.7	0	128	132	0	29	28
2025	11	24	21	1	10	24.5	-2.7	0.932	0.4	0.3	0	43	44.7	0	128	132	0	28	28
2025	11	24	21	11	10	25.7	-2.1	0.931	0.5	0.4	0	43	44.7	0	128	132	0	28	28
2025	11	24	21	21	10	24.8	-1.7	0.931	0.5	0.5	0	43	44.3	0	129	132	0	29	29
2025	11	24	21	31	10	24.8	-1.1	0.932	0.5	0.4	0	43	44.7	0	128	133	0	28	29
2025	11	24	21	41	10	24.9	-2	0.931	0.5	0.4	0	42.6	44.3	0	128	132	0	29	29
2025	11	24	21	51	10	25.4	-0.8	0.931	0.5	0.5	0	43.4	44.7	0	129	133	0	28	29
2025	11	24	22	1	10	24.5	-2.3	0.931	0.3	0.2	0	43.4	45.2	0	130	134	0	29	29
2025	11	24	22	11	10	25.2	-3.1	0.931	0.5	0.4	0	44.3	44.7	0	130	133	0	27	29
2025	11	24	22	21	10	24.1	-1.8	0.931	0.4	0.3	0	43.9	45.2	0	130	134	0	28	29
2025	11	24	22	31	10	24.5	-2.5	0.931	0.4	0.3	0	44.3	45.6	0	131	135	0	28	29
2025	11	24	22	41	10	24.6	-2.2	0.931	0.5	0.4	0	44.3	45.2	0	131	134	0	28	29
2025	11	24	22	51	10	24.8	-2.1	0.931	0.4	0.3	0	43.9	45.6	0	131	135	0	29	29
2025	11	24	23	1	10	24.1	-1.9	0.931	0.4	0.3	0	44.3	45.6	0	131	135	0	28	29
2025	11	24	23	11	10	25.3	-2.9	0.931	0.4	0.3	0	45.6	46.9	0	134	138	0	28	29
2025	11	24	23	21	10	25	-2.3	0.931	0.5	0.4	0	44.7	46	0	132	136	0	28	29
2025	11	24	23	31	10	25.1	-1.7	0.931	0.5	0.4	0	44.7	46	0	132	136	0	28	29
2025	11	24	23	41	10	24.4	-2.4	0.931	0.5	0.4	0	44.7	46.4	0	133	137	0	29	29
2025	11	24	23	51	10	23.9	-2.1	0.931	0.5	0.5	0	45.2	46.4	0	133	137	0	28	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	25	0	1	10	25.2	-2	0.931	0.4	0.3	0	44.3	46.4	0	132	137	0	29	29
2025	11	25	0	11	10	25.1	-2.4	0.931	0.4	0.3	0	44.3	46	0	132	136	0	29	29
2025	11	25	0	21	10	25.1	-1.9	0.931	0.5	0.4	0	44.3	46.4	0	132	137	0	29	29
2025	11	25	0	31	10	25.1	-2.7	0.931	0.5	0.5	0	44.3	46	0	132	136	0	29	29
2025	11	25	0	41	10	23.8	-1.6	0.931	0.5	0.4	0	45.2	46	0	133	136	0	28	29
2025	11	25	0	51	10	23.8	-2.3	0.931	0.5	0.5	0	44.3	46.4	0	132	137	0	29	29
2025	11	25	1	1	10	24.3	-1.6	0.931	0.5	0.4	0	44.3	46	0	132	136	0	29	29
2025	11	25	1	11	10	24.9	-2.5	0.931	0.5	0.4	0	44.7	46.4	0	132	136	0	28	28
2025	11	25	1	21	10	24.4	-1.9	0.931	0.5	0.4	0	44.3	46.4	0	132	136	0	29	28
2025	11	25	1	31	10	25	-1.2	0.931	0.4	0.3	0	44.3	46	0	132	136	0	29	29
2025	11	25	1	41	10	24.9	-2.2	0.931	0.4	0.3	0	44.7	46	0	132	136	0	28	29
2025	11	25	1	51	10	25.1	-2	0.931	0.5	0.4	0	43.9	45.6	0	131	135	0	29	29
2025	11	25	2	1	10	24.8	-2.1	0.931	0.3	0.2	0	44.3	45.6	0	131	135	0	28	29
2025	11	25	2	11	10	23.8	-2	0.93	0.5	0.4	0	43.9	46	0	131	135	0	29	28
2025	11	25	2	21	10	24.5	-2	0.931	0.5	0.4	0	44.3	45.6	0	131	135	0	28	29
2025	11	25	2	31	10	24.4	-2	0.93	0.4	0.3	0	43.9	45.6	0	130	135	0	28	29
2025	11	25	2	41	10	24.6	-1.9	0.93	0.4	0.3	0	43.9	45.6	0	131	135	0	29	29
2025	11	25	2	51	10	23.7	-1.8	0.93	0.4	0.3	0	43.9	45.6	0	131	135	0	29	29
2025	11	25	3	1	10	24.8	-2.1	0.93	0.4	0.3	0	43.4	45.6	0	130	135	0	29	29
2025	11	25	3	11	10	24.6	-2.1	0.93	0.5	0.4	0	43.4	45.2	0	130	134	0	29	29
2025	11	25	3	21	10	24.7	-3	0.93	0.5	0.5	0	43.9	45.2	0	130	134	0	28	29
2025	11	25	3	31	10	24.5	-2	0.93	0.4	0.3	0	43.4	45.2	0	130	134	0	29	29
2025	11	25	3	41	10	24.9	-1.7	0.93	0.3	0.2	0	43.9	45.2	0	130	134	0	28	29
2025	11	25	3	51	10	24.2	-2.2	0.93	0.4	0.3	0	43.4	45.2	0	130	134	0	29	29
2025	11	25	4	1	10	23.9	-2	0.93	0.5	0.4	0	43	44.7	0	129	133	0	29	29
2025	11	25	4	11	10	24.5	-2.7	0.93	0.3	0.2	0	43	44.7	0	129	133	0	29	29
2025	11	25	4	21	10	23.3	-1.6	0.93	0.5	0.5	0	43.9	45.2	0	130	134	0	28	29
2025	11	25	4	31	10	24.5	-2.6	0.93	0.5	0.5	0	43	44.3	0	129	133	0	29	30
2025	11	25	4	41	10	24.9	-2.6	0.93	0.5	0.4	0	43	44.7	0	129	133	0	29	29
2025	11	25	4	51	10	24.2	-1.9	0.93	0.3	0.2	0	43	44.7	0	129	133	0	29	29
2025	11	25	5	1	10	25.3	-3.1	0.93	0.4	0.3	0	43.4	44.7	0	129	133	0	28	29
2025	11	25	5	11	10	24.7	-2.5	0.93	0.4	0.3	0	43	44.7	0	129	133	0	29	29
2025	11	25	5	21	10	25.7	-3.3	0.93	0.4	0.3	0	42.6	44.7	0	128	133	0	29	29
2025	11	25	5	31	10	25	-3	0.93	0.5	0.5	0	43.4	44.3	0	129	132	0	28	29
2025	11	25	5	41	10	24.4	-1.6	0.93	0.5	0.5	0	43.4	44.7	0	129	133	0	28	29
2025	11	25	5	51	10	24.5	-2.4	0.93	0.4	0.3	0	43	44.7	0	129	133	0	29	29
2025	11	25	6	1	10	24.3	-2.1	0.93	0.5	0.5	0	43	45.2	0	129	133	0	29	28
2025	11	25	6	11	10	24.3	-1.5	0.93	0.3	0.2	0	42.6	44.3	0	128	132	0	29	29
2025	11	25	6	21	10	25	-3.2	0.93	0.5	0.5	0	43	44.3	0	128	132	0	28	29
2025	11	25	6	31	10	24.7	-0.3	0.93	0.4	0.3	0	42.6	44.3	0	128	132	0	29	29
2025	11	25	6	41	10	25.1	-1.5	0.93	0.4	0.3	0	43	44.3	0	128	132	0	28	29
2025	11	25	6	51	10	24.5	-2.2	0.93	0.3	0.2	0	42.1	44.3	0	127	132	0	29	29
2025	11	25	7	1	10	25.6	-3.2	0.93	0.5	0.4	0	43	43.9	0	128	132	0	28	30
2025	11	25	7	11	10	23.7	-2.2	0.93	0.4	0.3	0	42.6	44.3	0	128	132	0	29	29
2025	11	25	7	21	10	25.3	-2.2	0.93	0.5	0.4	0	43	44.3	0	128	132	0	28	29
2025	11	25	7	31	10	25.1	-2.9	0.93	0.5	0.4	0	42.1	44.3	0	127	132	0	29	29
2025	11	25	7	41	10	24.4	-2.1	0.93	0.5	0.4	0	42.6	44.3	0	128	132	0	29	29
2025	11	25	7	51	10	24.6	-2	0.93	0.4	0.3	0	42.1	43.9	0	127	131	0	29	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	25	8	1	10	24.2	-2	0.93	0.4	0.3	0	42.1	44.3	0	127	132	0	29	29
2025	11	25	8	11	10	23.7	-3	0.93	0.5	0.5	0	42.6	43.9	0	127	131	0	28	29
2025	11	25	8	21	10	24.4	-2.5	0.93	0.5	0.5	0	41.7	43	0	126	130	0	29	30
2025	11	25	8	31	10	25.7	-1.6	0.93	0.4	0.3	0	41.7	43.4	0	126	130	0	29	29
2025	11	25	8	41	10	25	-1.6	0.93	0.5	0.4	0	41.7	43.9	0	126	131	0	29	29
2025	11	25	8	51	10	24.4	-2.1	0.93	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	25	9	1	10	23.9	-2.4	0.93	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	25	9	11	10	23.8	-1.6	0.93	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	25	9	21	10	23.4	-2.2	0.93	0.4	0.3	0	41.3	43	0	125	129	0	29	29
2025	11	25	9	31	10	24.9	-3.7	0.93	0.3	0.2	0	41.3	43	0	125	129	0	29	29
2025	11	25	9	41	10	23.1	-1.6	0.93	0.5	0.4	0	42.1	43.4	0	127	130	0	29	29
2025	11	25	9	51	10	24.1	-2.4	0.93	0.4	0.3	0	42.1	43.4	0	126	130	0	28	29
2025	11	25	10	1	10	24.3	-1.8	0.93	0.5	0.4	0	41.3	43.4	0	125	130	0	29	29
2025	11	25	10	11	10	24.9	-2	0.93	0.5	0.5	0	41.3	43	0	125	129	0	29	29
2025	11	25	10	21	10	23.9	-2.5	0.93	0.5	0.4	0	41.3	42.6	0	125	129	0	29	30
2025	11	25	10	31	10	24.9	-2.4	0.93	0.5	0.4	0	41.3	43	0	125	129	0	29	29
2025	11	25	10	41	10	25.7	-2.4	0.93	0.5	0.4	0	42.6	44.3	0	128	132	0	29	29
2025	11	25	10	51	10	23.6	-2.5	0.93	0.5	0.4	0	41.7	43	0	126	130	0	29	30
2025	11	25	11	1	10	24.6	-2.8	0.93	0.5	0.4	0	41.3	42.6	0	125	129	0	29	30
2025	11	25	11	11	10	24.1	-0.6	0.93	0.5	0.4	0	41.3	43	0	125	129	0	29	29
2025	11	25	11	21	10	25	-2.3	0.93	0.4	0.3	0	41.7	43	0	125	129	0	28	29
2025	11	25	11	31	10	24.7	-2.8	0.93	0.5	0.4	0	41.3	42.6	0	125	129	0	29	30
2025	11	25	11	41	10	24.5	-2	0.931	0.3	0.2	0	41.7	43.4	0	125	129	0	28	28
2025	11	25	11	51	10	23.6	-1.9	0.931	0.4	0.3	0	40.9	43	0	124	128	0	29	28
2025	11	25	12	1	10	24.3	-2.1	0.931	0.4	0.3	0	40.9	42.6	0	124	128	0	29	29
2025	11	25	12	11	10	24.9	-1.7	0.931	0.5	0.4	0	40.9	42.6	0	124	128	0	29	29
2025	11	25	12	21	10	24	-1.8	0.931	0.4	0.3	0	41.3	42.6	0	124	128	0	28	29
2025	11	25	12	31	10	23.7	-1.6	0.931	0.5	0.4	0	40.9	42.6	0	124	128	0	29	29
2025	11	25	12	41	10	24.9	-1.2	0.931	0.5	0.4	0	41.7	42.6	0	125	128	0	28	29
2025	11	25	12	51	10	24.4	-3	0.931	0.5	0.4	0	42.1	43.4	0	126	130	0	28	29
2025	11	25	13	1	10	23.9	-2.3	0.931	0.4	0.3	0	42.1	43.4	0	126	130	0	28	29
2025	11	25	13	11	10	23.6	-2.9	0.932	0.3	0.2	0	42.1	43.4	0	126	130	0	28	29
2025	11	25	13	21	10	25.3	-2.1	0.932	0.5	0.4	0	41.3	43	0	125	129	0	29	29
2025	11	25	13	31	10	23.9	-3.4	0.932	0.5	0.4	0	41.7	43	0	125	129	0	28	29
2025	11	25	13	41	10	25.5	-2	0.932	0.5	0.4	0	41.3	43	0	125	129	0	29	29
2025	11	25	13	51	10	25.8	-1.1	0.932	0.4	0.3	0	41.7	42.6	0	125	128	0	28	29
2025	11	25	14	1	10	24.4	-2.8	0.932	0.3	0.2	0	40.9	42.6	0	124	129	0	29	30
2025	11	25	14	11	10	23.9	-2.8	0.933	0.5	0.4	0	41.7	43	0	125	129	0	28	29
2025	11	25	14	21	10	24.4	-2.3	0.933	0.5	0.4	0	40.9	42.6	0	124	128	0	29	29
2025	11	25	14	31	10	24.2	-2	0.933	0.3	0.2	0	41.3	42.6	0	124	128	0	28	29
2025	11	25	14	41	10	25.1	-1.9	0.933	0.5	0.4	0	40.9	42.6	0	124	128	0	29	29
2025	11	25	14	51	10	24.6	-1.6	0.933	0.5	0.4	0	40.9	42.1	0	123	127	0	28	29
2025	11	25	15	1	10	24.1	-1.6	0.933	0.4	0.3	0	41.3	42.6	0	124	128	0	28	29
2025	11	25	15	11	10	25.1	-2.4	0.933	0.5	0.4	0	40.4	42.6	0	123	128	0	29	29
2025	11	25	15	21	10	25.2	-2.3	0.933	0.5	0.4	0	40.9	42.6	0	124	128	0	29	29
2025	11	25	15	31	10	24.8	-0.9	0.933	0.5	0.4	0	41.3	42.6	0	124	128	0	28	29
2025	11	25	15	41	10	24.6	-2.1	0.934	0.3	0.2	0	40.9	42.6	0	124	128	0	29	29
2025	11	25	15	51	10	24.6	-2.8	0.934	0.5	0.4	0	41.3	42.6	0	124	129	0	28	30

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	25	16	1	10	23.4	-1.9	0.934	0.5	0.4	0	40.9	42.6	0	124	128	0	29	29
2025	11	25	16	11	10	23.5	-1.7	0.934	0.4	0.3	0	41.7	43	0	125	129	0	28	29
2025	11	25	16	21	10	24.9	-2.6	0.934	0.4	0.3	0	41.3	43	0	125	129	0	29	29
2025	11	25	16	31	10	25.8	-1.7	0.934	0.4	0.3	0	41.3	43	0	124	129	0	28	29
2025	11	25	16	41	10	24.9	-2.1	0.934	0.5	0.4	0	41.7	43.4	0	125	129	0	28	28
2025	11	25	16	51	10	24.9	-2.3	0.934	0.5	0.4	0	41.7	43	0	126	129	0	29	29
2025	11	25	17	1	10	24.4	-2.9	0.935	0.4	0.3	0	41.7	43	0	125	129	0	28	29
2025	11	25	17	11	10	24.1	-2.3	0.935	0.5	0.5	0	41.7	43	0	125	129	0	28	29
2025	11	25	17	21	10	24.4	-2.8	0.935	0.5	0.4	0	41.3	43	0	124	129	0	28	29
2025	11	25	17	31	10	25.5	-2.1	0.935	0.5	0.5	0	41.7	42.6	0	125	128	0	28	29
2025	11	25	17	41	10	23.6	-1.6	0.935	0.5	0.5	0	41.3	43	0	124	129	0	28	29
2025	11	25	17	51	10	25.5	-3.1	0.935	0.5	0.5	0	41.3	43	0	125	129	0	29	29
2025	11	25	18	1	10	24.8	-3	0.936	0.5	0.4	0	41.7	43.4	0	125	129	0	28	28
2025	11	25	18	11	10	25	-1.7	0.936	0.4	0.3	0	41.7	43.4	0	125	130	0	28	29
2025	11	25	18	21	10	24.7	-1.3	0.937	0.5	0.4	0	42.1	43.9	0	126	131	0	28	29
2025	11	25	18	31	10	25.3	-3.7	0.938	0.3	0.2	0	42.6	43.9	0	127	131	0	28	29
2025	11	25	18	41	10	25.7	-2.1	0.939	0.6	0.5	0	42.6	43.9	0	127	131	0	28	29
2025	11	25	18	51	10	23.9	-1.6	0.939	0.5	0.4	0	43	44.3	0	128	132	0	28	29
2025	11	25	19	1	10	25.1	-1.6	0.939	0.4	0.3	0	42.6	44.3	0	128	132	0	29	29
2025	11	25	19	11	10	25	-2.9	0.94	0.5	0.4	0	43	44.3	0	128	132	0	28	29
2025	11	25	19	21	10	25.4	-2.8	0.94	0.4	0.3	0	42.1	43.9	0	127	131	0	29	29
2025	11	25	19	31	10	26.1	-1.4	0.94	0.5	0.4	0	42.1	44.3	0	127	131	0	29	28
2025	11	25	19	41	10	25.3	-3.5	0.94	0.4	0.3	0	42.6	43.9	0	127	131	0	28	29
2025	11	25	19	51	10	25.3	-2.1	0.94	0.5	0.4	0	42.6	43.9	0	127	131	0	28	29
2025	11	25	20	1	10	24.3	-2.4	0.94	0.5	0.5	0	42.6	43.9	0	127	131	0	28	29
2025	11	25	20	11	10	24.8	-1.7	0.94	0.5	0.5	0	42.1	44.3	0	127	131	0	29	28
2025	11	25	20	21	10	25.2	-2	0.941	0.5	0.4	0	43	43.9	0	128	131	0	28	29
2025	11	25	20	31	10	25.4	-2	0.941	0.5	0.4	0	42.1	44.3	0	127	131	0	29	28
2025	11	25	20	41	10	24.1	-2.5	0.941	0.5	0.5	0	42.6	44.3	0	127	131	0	28	28
2025	11	25	20	51	10	25.3	-2.9	0.941	0.5	0.4	0	42.1	43.9	0	127	131	0	29	29
2025	11	25	21	1	10	24.9	-1.6	0.941	0.4	0.3	0	42.6	43.4	0	127	131	0	28	30
2025	11	25	21	11	10	25.2	-3.1	0.941	0.4	0.3	0	42.6	44.3	0	128	132	0	29	29
2025	11	25	21	21	10	24.4	-2.9	0.941	0.5	0.4	0	42.6	44.3	0	128	132	0	29	29
2025	11	25	21	31	10	26.2	-1.9	0.941	0.5	0.4	0	42.6	44.7	0	127	132	0	28	28
2025	11	25	21	41	10	25.1	-3	0.941	0.5	0.4	0	43	44.7	0	128	132	0	28	28
2025	11	25	21	51	10	26	-1.6	0.941	0.5	0.4	0	42.6	44.3	0	128	132	0	29	29
2025	11	25	22	1	10	25.1	-1.2	0.941	0.5	0.4	0	43	44.7	0	128	133	0	28	29
2025	11	25	22	11	10	26	-2.4	0.941	0.4	0.3	0	42.6	44.3	0	128	132	0	29	29
2025	11	25	22	21	10	26.3	-1.8	0.941	0.5	0.5	0	42.6	43.9	0	128	132	0	29	30
2025	11	25	22	31	10	24.8	-2.3	0.941	0.5	0.4	0	43	44.7	0	129	133	0	29	29
2025	11	25	22	41	10	25.6	-1.9	0.941	0.5	0.5	0	43.4	44.7	0	129	133	0	28	29
2025	11	25	22	51	10	25.3	-2.3	0.941	0.5	0.4	0	43	44.7	0	129	133	0	29	29
2025	11	25	23	1	10	24.8	-1.5	0.941	0.4	0.3	0	43.4	44.7	0	129	133	0	28	29
2025	11	25	23	11	10	24.5	-2.9	0.941	0.4	0.3	0	43	44.7	0	129	133	0	29	29
2025	11	25	23	21	10	25.3	-2.4	0.941	0.5	0.5	0	43.4	45.2	0	129	133	0	28	28
2025	11	25	23	31	10	25.6	-2.3	0.941	0.5	0.5	0	43	45.2	0	129	134	0	29	29
2025	11	25	23	41	10	25.6	-2.6	0.941	0.5	0.4	0	43	45.2	0	129	134	0	29	29
2025	11	25	23	51	10	24.6	-2.5	0.941	0.5	0.4	0	43.4	45.2	0	129	134	0	28	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	26	0	1	10	24.3	-2.4	0.941	0.4	0.3	0	43	45.2	0	129	134	0	29	29
2025	11	26	0	11	10	24.7	-2.6	0.941	0.4	0.3	0	43	44.7	0	129	133	0	29	29
2025	11	26	0	21	10	25.5	-2.6	0.941	0.3	0.2	0	43	44.7	0	129	133	0	29	29
2025	11	26	0	31	10	25.8	-1.9	0.941	0.5	0.4	0	43	44.7	0	129	133	0	29	29
2025	11	26	0	41	10	25.2	-3.2	0.941	0.5	0.4	0	43.9	45.2	0	130	134	0	28	29
2025	11	26	0	51	10	25.4	-1.7	0.941	0.3	0.2	0	43	45.2	0	129	134	0	29	29
2025	11	26	1	1	10	24.5	-2.1	0.942	0.5	0.4	0	43	45.2	0	129	134	0	29	29
2025	11	26	1	11	10	23.6	-2.7	0.941	0.3	0.2	0	43	44.7	0	129	134	0	29	30
2025	11	26	1	21	10	25.6	-3.2	0.942	0.5	0.5	0	43.9	45.2	0	130	134	0	28	29
2025	11	26	1	31	10	24.8	-2.3	0.941	0.4	0.3	0	43	45.2	0	129	134	0	29	29
2025	11	26	1	41	10	25.1	-2.3	0.941	0.5	0.5	0	43	44.7	0	129	133	0	29	29
2025	11	26	1	51	10	25.3	-3	0.941	0.5	0.5	0	43	45.2	0	129	133	0	29	28
2025	11	26	2	1	10	25.7	-2.3	0.941	0.5	0.4	0	43	44.3	0	129	133	0	29	30
2025	11	26	2	11	10	25.5	-2.5	0.942	0.3	0.2	0	43	44.7	0	129	133	0	29	29
2025	11	26	2	21	10	25.4	-1.6	0.942	0.5	0.4	0	43	44.7	0	129	133	0	29	29
2025	11	26	2	31	10	24.7	-2.4	0.941	0.4	0.3	0	43	45.2	0	129	133	0	29	28
2025	11	26	2	41	10	24.2	-2	0.942	0.3	0.2	0	43	44.7	0	129	133	0	29	29
2025	11	26	2	51	10	25	-2.2	0.942	0.3	0.2	0	43.4	44.7	0	129	133	0	28	29
2025	11	26	3	1	10	25.7	-1.8	0.942	0.5	0.4	0	43.4	44.7	0	129	133	0	28	29
2025	11	26	3	11	10	23.5	-0.8	0.942	0.3	0.2	0	43	44.7	0	129	133	0	29	29
2025	11	26	3	21	10	25.7	-1.4	0.942	0.5	0.4	0	43	44.3	0	129	133	0	29	30
2025	11	26	3	31	10	24.9	-3.2	0.942	0.5	0.5	0	42.6	44.7	0	128	133	0	29	29
2025	11	26	3	41	10	24.5	-2.4	0.942	0.3	0.2	0	42.6	44.3	0	128	133	0	29	30
2025	11	26	3	51	10	25.3	-2.1	0.941	0.4	0.3	0	42.6	44.7	0	128	133	0	29	29
2025	11	26	4	1	10	25.2	-2	0.942	0.4	0.3	0	42.6	44.7	0	128	133	0	29	29
2025	11	26	4	11	10	24.6	-2.4	0.942	0.5	0.5	0	42.6	44.7	0	128	133	0	29	29
2025	11	26	4	21	10	24.7	-2.7	0.942	0.5	0.5	0	42.6	44.3	0	128	133	0	29	30
2025	11	26	4	31	10	24.5	-1.6	0.942	0.4	0.3	0	42.6	44.7	0	128	133	0	29	29
2025	11	26	4	41	10	26.2	-0.8	0.942	0.5	0.5	0	42.6	45.2	0	128	133	0	29	28
2025	11	26	4	51	10	25.6	-3.1	0.942	0.5	0.4	0	43	44.7	0	129	133	0	29	29
2025	11	26	5	1	10	25.3	-2.1	0.942	0.5	0.4	0	43	44.7	0	128	133	0	28	29
2025	11	26	5	11	10	25.1	-2	0.942	0.4	0.3	0	43	44.3	0	128	132	0	28	29
2025	11	26	5	21	10	24.6	-2.1	0.942	0.5	0.4	0	42.6	43.9	0	128	132	0	29	30
2025	11	26	5	31	10	24.9	-2.1	0.942	0.5	0.5	0	43	44.3	0	128	132	0	28	29
2025	11	26	5	41	10	25.2	-3.1	0.942	0.3	0.2	0	42.6	44.3	0	128	132	0	29	29
2025	11	26	5	51	10	25.2	-2.3	0.942	0.4	0.3	0	43	44.7	0	129	133	0	29	29
2025	11	26	6	1	10	25.3	-2.5	0.941	0.4	0.3	0	42.6	43.9	0	128	132	0	29	30
2025	11	26	6	11	10	26.2	-1.6	0.942	0.5	0.5	0	42.6	44.3	0	128	132	0	29	29
2025	11	26	6	21	10	24.9	-1.6	0.942	0.4	0.3	0	42.6	44.3	0	128	133	0	29	30
2025	11	26	6	31	10	24	-1.6	0.942	0.4	0.3	0	43	44.3	0	128	133	0	28	30
2025	11	26	6	41	10	25.2	-1.4	0.942	0.4	0.3	0	42.6	44.3	0	128	132	0	29	29
2025	11	26	6	51	10	25.1	-3.1	0.942	0.5	0.5	0	42.6	43.9	0	128	132	0	29	30
2025	11	26	7	1	10	24.7	-1.6	0.942	0.5	0.4	0	42.6	44.3	0	128	132	0	29	29
2025	11	26	7	11	10	25.7	-1.5	0.941	0.5	0.4	0	42.1	43.9	0	127	131	0	29	29
2025	11	26	7	21	10	25.2	-2.4	0.942	0.5	0.4	0	42.6	44.3	0	127	132	0	28	29
2025	11	26	7	31	10	25.2	-2.3	0.942	0.5	0.4	0	42.1	43.9	0	127	131	0	29	29
2025	11	26	7	41	10	24.4	-2	0.942	0.5	0.5	0	42.6	44.3	0	127	132	0	28	29
2025	11	26	7	51	10	24.4	-2	0.942	0.4	0.3	0	42.6	43.9	0	127	131	0	28	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	26	8	1	10	25.2	-2.3	0.942	0.5	0.4	0	42.1	43.9	0	127	131	0	29	29
2025	11	26	8	11	10	24.3	-2.1	0.942	0.5	0.4	0	41.7	43.9	0	126	131	0	29	29
2025	11	26	8	21	10	25.2	-2.6	0.941	0.3	0.2	0	42.1	43.9	0	126	131	0	28	29
2025	11	26	8	31	10	25	-3.2	0.942	0.4	0.3	0	42.1	43.4	0	127	131	0	29	30
2025	11	26	8	41	10	25.7	-2.4	0.941	0.5	0.4	0	42.1	43.9	0	127	131	0	29	29
2025	11	26	8	51	10	26.3	-2.4	0.942	0.5	0.4	0	42.1	43.4	0	127	131	0	29	30
2025	11	26	9	1	10	25.6	-3.2	0.942	0.5	0.4	0	42.6	44.3	0	128	132	0	29	29
2025	11	26	9	11	10	25.2	-2.8	0.942	0.3	0.2	0	42.1	43.9	0	127	131	0	29	29
2025	11	26	9	21	10	25	-3	0.942	0.4	0.3	0	41.7	43.4	0	126	130	0	29	29
2025	11	26	9	31	10	26.4	-2.3	0.942	0.5	0.5	0	41.7	43.4	0	125	130	0	28	29
2025	11	26	9	41	10	24	-2.1	0.942	0.6	0.5	0	41.3	43.4	0	125	130	0	29	29
2025	11	26	9	51	10	24.5	-1.9	0.942	0.5	0.4	0	41.7	43	0	126	129	0	29	29
2025	11	26	10	1	10	25.5	-3.5	0.942	0.5	0.5	0	41.3	43	0	125	129	0	29	29
2025	11	26	10	11	10	26	-2	0.942	0.5	0.5	0	41.3	43	0	125	129	0	29	29
2025	11	26	10	21	10	25	-2.8	0.942	0.4	0.3	0	41.7	42.6	0	125	129	0	28	30
2025	11	26	10	31	10	24.4	-3.2	0.942	0.4	0.3	0	41.3	43	0	125	129	0	29	29
2025	11	26	10	41	10	24	-2.4	0.942	0.4	0.3	0	41.3	43.4	0	125	130	0	29	29
2025	11	26	10	51	10	23.8	-2.9	0.942	0.4	0.3	0	42.1	43.4	0	126	130	0	28	29
2025	11	26	11	1	10	25.4	-2	0.942	0.5	0.4	0	42.1	43.9	0	126	131	0	28	29
2025	11	26	11	11	10	24.8	-2.8	0.942	0.4	0.3	0	41.7	43	0	125	129	0	28	29
2025	11	26	11	21	10	25.3	-2.4	0.942	0.4	0.3	0	41.3	43	0	125	129	0	29	29
2025	11	26	11	31	10	26.6	-2.1	0.942	0.5	0.4	0	40.9	42.6	0	124	128	0	29	29
2025	11	26	11	41	10	24.9	-2.7	0.942	0.5	0.4	0	41.3	42.6	0	125	128	0	29	29
2025	11	26	11	51	10	26	-1.7	0.942	0.5	0.4	0	44.3	46	0	132	136	0	29	29
2025	11	26	12	1	10	24.7	-2.4	0.942	0.5	0.4	0	42.1	43.9	0	127	131	0	29	29
2025	11	26	12	11	10	24.7	-2.8	0.942	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	26	12	21	10	25.2	-2.7	0.943	0.5	0.4	0	41.3	42.6	0	125	128	0	29	29
2025	11	26	12	31	10	25.5	-2.4	0.943	0.5	0.4	0	40.4	41.7	0	123	127	0	29	30
2025	11	26	12	41	10	26.3	-1.2	0.943	0.5	0.4	0	40.9	41.7	0	124	127	0	29	30
2025	11	26	12	51	10	24.4	-3.2	0.943	0.5	0.4	0	41.3	43	0	125	129	0	29	29
2025	11	26	13	1	10	23.9	-2.9	0.943	0.5	0.4	0	40.9	42.6	0	124	128	0	29	29
2025	11	26	13	11	10	25.5	-2.3	0.943	0.5	0.4	0	41.3	43	0	125	129	0	29	29
2025	11	26	13	21	10	24.9	-2.4	0.943	0.4	0.3	0	42.1	44.3	0	127	132	0	29	29
2025	11	26	13	31	10	25.9	-2.7	0.943	0.4	0.3	0	41.7	43	0	126	130	0	29	30
2025	11	26	13	41	10	24.9	-2.2	0.943	0.5	0.4	0	43.4	43.9	0	129	132	0	28	30
2025	11	26	13	51	10	25.7	-0.8	0.943	0.4	0.3	0	43.4	45.2	0	129	134	0	28	29
2025	11	26	14	1	10	25.5	-2.1	0.943	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	26	14	11	10	25.3	-2.1	0.943	0.5	0.5	0	41.7	43.4	0	126	130	0	29	29
2025	11	26	14	21	10	25.8	-1.6	0.943	0.6	0.5	0	41.7	43.4	0	126	130	0	29	29
2025	11	26	14	31	10	25.3	-1.7	0.943	0.5	0.4	0	42.1	43.4	0	126	130	0	28	29
2025	11	26	14	41	10	25.1	-1.9	0.943	0.5	0.4	0	43	44.3	0	128	132	0	28	29
2025	11	26	14	51	10	24.7	-1.2	0.943	0.5	0.4	0	43	44.7	0	129	133	0	29	29
2025	11	26	15	1	10	24.6	-1.4	0.944	0.5	0.4	0	43	44.7	0	129	133	0	29	29
2025	11	26	15	11	10	25.1	-2.1	0.944	0.5	0.5	0	42.6	44.7	0	128	133	0	29	29
2025	11	26	15	21	10	25	-1.6	0.943	0.4	0.3	0	43.4	44.7	0	129	133	0	28	29
2025	11	26	15	31	10	25.3	-2.9	0.944	0.5	0.4	0	42.6	44.3	0	127	131	0	28	28
2025	11	26	15	41	10	24.7	-1.8	0.944	0.4	0.3	0	42.6	44.7	0	128	133	0	29	29
2025	11	26	15	51	10	24.6	-1.4	0.944	0.5	0.5	0	43.9	45.6	0	130	134	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	26	16	1	10	25.5	-2.6	0.944	0.4	0.3	0	43.4	45.2	0	130	133	0	29	28
2025	11	26	16	11	10	25	-1.9	0.944	0.4	0.3	0	43.9	45.2	0	130	134	0	28	29
2025	11	26	16	21	10	25.4	-2.4	0.944	0.4	0.3	0	43.9	45.2	0	130	134	0	28	29
2025	11	26	16	31	10	24.2	-1.9	0.944	0.4	0.3	0	43	44.7	0	129	133	0	29	29
2025	11	26	16	41	10	23.4	-2.5	0.944	0.4	0.3	0	43.9	45.2	0	130	134	0	28	29
2025	11	26	16	51	10	24.6	-2.1	0.944	0.5	0.4	0	43.4	45.2	0	130	134	0	29	29
2025	11	26	17	1	10	25.4	-2.7	0.944	0.5	0.4	0	43.4	45.6	0	129	134	0	28	28
2025	11	26	17	11	10	25.4	-3	0.944	0.4	0.3	0	43	45.2	0	129	134	0	29	29
2025	11	26	17	21	10	25.2	-2.1	0.944	0.6	0.5	0	43.9	45.6	0	130	134	0	28	28
2025	11	26	17	31	10	24.7	-1.6	0.944	0.4	0.3	0	43.4	45.2	0	130	134	0	29	29
2025	11	26	17	41	10	24.2	-2.5	0.944	0.3	0.2	0	43	44.7	0	129	133	0	29	29
2025	11	26	17	51	10	25.9	-1.6	0.944	0.5	0.4	0	43	44.3	0	128	132	0	28	29
2025	11	26	18	1	10	25.5	-2.1	0.944	0.4	0.3	0	42.6	44.3	0	127	132	0	28	29
2025	11	26	18	11	10	25	-2.6	0.944	0.3	0.2	0	42.6	44.3	0	127	131	0	28	28
2025	11	26	18	21	10	24.8	-0.8	0.944	0.5	0.4	0	43	43.9	0	127	131	0	27	29
2025	11	26	18	31	10	25.1	-2.1	0.944	0.5	0.4	0	42.6	44.3	0	128	132	0	29	29
2025	11	26	18	41	10	25.9	-2.5	0.944	0.5	0.4	0	43	44.7	0	128	132	0	28	28
2025	11	26	18	51	10	25.4	-3.1	0.944	0.5	0.4	0	42.6	44.3	0	128	132	0	29	29
2025	11	26	19	1	10	25	-2.6	0.944	0.4	0.3	0	43	44.3	0	128	132	0	28	29
2025	11	26	19	11	10	25.7	-1.8	0.944	0.5	0.4	0	42.6	44.3	0	128	132	0	29	29
2025	11	26	19	21	10	25	-2.3	0.944	0.5	0.5	0	42.6	44.3	0	128	132	0	29	29
2025	11	26	19	31	10	25	-2.9	0.944	0.5	0.4	0	42.1	44.3	0	127	132	0	29	29
2025	11	26	19	41	10	25.3	-1.4	0.944	0.5	0.4	0	42.6	44.7	0	128	132	0	29	28
2025	11	26	19	51	10	25.1	-2.5	0.944	0.5	0.4	0	42.6	43.9	0	127	131	0	28	29
2025	11	26	20	1	10	24.5	-1.2	0.944	0.5	0.4	0	42.6	43.9	0	127	131	0	28	29
2025	11	26	20	11	10	25.7	-2.4	0.944	0.5	0.4	0	42.1	44.3	0	126	131	0	28	28
2025	11	26	20	21	10	24.9	-2	0.943	0.5	0.4	0	42.1	43.9	0	127	131	0	29	29
2025	11	26	20	31	10	26.1	-2	0.944	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	26	20	41	10	25.4	-2.2	0.944	0.3	0.2	0	42.1	43.9	0	126	131	0	28	29
2025	11	26	20	51	10	25.3	-1.4	0.944	0.4	0.3	0	42.6	43.4	0	127	131	0	28	30
2025	11	26	21	1	10	24.5	-2.3	0.944	0.4	0.3	0	42.6	43.9	0	127	131	0	28	29
2025	11	26	21	11	10	25.1	-1.4	0.944	0.4	0.3	0	42.1	43.9	0	127	131	0	29	29
2025	11	26	21	21	10	25.9	-1.1	0.944	0.5	0.5	0	42.1	43.9	0	127	131	0	29	29
2025	11	26	21	31	10	26.3	-2	0.943	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	26	21	41	10	24.3	-0.9	0.943	0.5	0.4	0	42.1	43.9	0	127	131	0	29	29
2025	11	26	21	51	10	26.1	-2	0.944	0.5	0.4	0	42.1	43.9	0	126	131	0	28	29
2025	11	26	22	1	10	25.8	-2.1	0.943	0.5	0.4	0	43	43.9	0	127	131	0	27	29
2025	11	26	22	11	10	25	-2.6	0.943	0.4	0.3	0	42.1	43.9	0	127	131	0	29	29
2025	11	26	22	21	10	25.2	-2	0.943	0.5	0.5	0	42.1	43.4	0	126	130	0	28	29
2025	11	26	22	31	10	24.9	-2.2	0.943	0.5	0.4	0	42.1	43.9	0	126	131	0	28	29
2025	11	26	22	41	10	25.2	-1.3	0.943	0.5	0.5	0	41.7	43.4	0	126	131	0	29	30
2025	11	26	22	51	10	25.6	-1.2	0.943	0.5	0.4	0	42.1	43.9	0	126	131	0	28	29
2025	11	26	23	1	10	26.3	-3.2	0.943	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	26	23	11	10	23.8	-2.3	0.943	0.4	0.3	0	41.7	43.9	0	126	131	0	29	29
2025	11	26	23	21	10	25.9	-2.2	0.943	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	26	23	31	10	24.3	-1.8	0.943	0.4	0.3	0	42.1	43.4	0	126	130	0	28	29
2025	11	26	23	41	10	25.1	-2.1	0.943	0.5	0.4	0	42.1	43.4	0	126	130	0	28	29
2025	11	26	23	51	10	25	-2.4	0.943	0.5	0.4	0	41.7	43.9	0	126	131	0	29	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	27	0	1	10	24.8	-1.6	0.943	0.4	0.3	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	0	11	10	25.4	-2.8	0.943	0.5	0.4	0	41.7	43.4	0	125	130	0	28	29
2025	11	27	0	21	10	25	-2.1	0.943	0.4	0.3	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	0	31	10	25.7	-1.4	0.943	0.5	0.4	0	41.3	43.4	0	125	130	0	29	29
2025	11	27	0	41	10	25.4	-2.2	0.943	0.4	0.3	0	42.1	43.4	0	126	130	0	28	29
2025	11	27	0	51	10	25	-2.1	0.943	0.5	0.4	0	42.1	43.9	0	127	131	0	29	29
2025	11	27	1	1	10	26.3	-2.2	0.943	0.5	0.4	0	42.1	43.9	0	126	131	0	28	29
2025	11	27	1	11	10	25.2	-2.7	0.943	0.4	0.3	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	1	21	10	26.5	-1.9	0.943	0.4	0.3	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	1	31	10	25.7	-2.5	0.942	0.4	0.3	0	41.7	43	0	126	130	0	29	30
2025	11	27	1	41	10	25	-2.4	0.943	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	1	51	10	25.8	-2.5	0.943	0.4	0.3	0	41.7	43.4	0	125	130	0	28	29
2025	11	27	2	1	10	24.8	-2	0.942	0.5	0.4	0	41.7	43	0	126	130	0	29	30
2025	11	27	2	11	10	24.4	-2.2	0.942	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	2	21	10	25.1	-1.8	0.942	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	2	31	10	24.1	-2	0.942	0.4	0.3	0	41.3	43.4	0	125	130	0	29	29
2025	11	27	2	41	10	25.4	-1.9	0.943	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	2	51	10	24.8	-2.8	0.942	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	3	1	10	24.9	-1.8	0.942	0.4	0.3	0	41.3	43.9	0	125	130	0	29	28
2025	11	27	3	11	10	25.3	-1.3	0.942	0.5	0.4	0	41.3	43.4	0	125	130	0	29	29
2025	11	27	3	21	10	25	-2.5	0.942	0.3	0.2	0	41.7	43.4	0	125	130	0	28	29
2025	11	27	3	31	10	25.5	-1.7	0.942	0.5	0.4	0	41.7	43	0	126	130	0	29	30
2025	11	27	3	41	10	24.8	-1.6	0.942	0.4	0.3	0	41.7	43	0	126	130	0	29	30
2025	11	27	3	51	10	25.1	-2.8	0.942	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	4	1	10	25.3	-1.3	0.942	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	4	11	10	26.9	-2.6	0.942	0.5	0.4	0	41.3	43	0	125	130	0	29	30
2025	11	27	4	21	10	25.4	-2.4	0.942	0.5	0.4	0	41.7	43.4	0	125	130	0	28	29
2025	11	27	4	31	10	26	-2.8	0.942	0.5	0.4	0	41.3	43.4	0	125	130	0	29	29
2025	11	27	4	41	10	24.6	-2.6	0.942	0.4	0.3	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	4	51	10	25.3	-2.8	0.942	0.5	0.4	0	41.7	43.4	0	125	130	0	28	29
2025	11	27	5	1	10	25.9	-2.6	0.942	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	5	11	10	25	-1.1	0.942	0.5	0.5	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	5	21	10	23.6	-2.7	0.942	0.5	0.4	0	42.1	43.9	0	126	131	0	28	29
2025	11	27	5	31	10	26.3	-3.1	0.942	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	5	41	10	24.8	-3.4	0.942	0.6	0.5	0	41.3	43.4	0	125	130	0	29	29
2025	11	27	5	51	10	24.8	-2.6	0.942	0.4	0.3	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	6	1	10	24.5	-2.7	0.941	0.4	0.3	0	41.3	43.4	0	125	130	0	29	29
2025	11	27	6	11	10	25.2	-3.2	0.941	0.5	0.4	0	41.3	43.4	0	125	130	0	29	29
2025	11	27	6	21	10	24.8	-2.2	0.941	0.4	0.3	0	41.3	43.4	0	125	130	0	29	29
2025	11	27	6	31	10	24.1	-2.4	0.941	0.4	0.3	0	41.3	43.4	0	125	130	0	29	29
2025	11	27	6	41	10	25.4	-1.8	0.941	0.5	0.4	0	41.3	43.4	0	125	130	0	29	29
2025	11	27	6	51	10	25.1	-2.3	0.941	0.5	0.5	0	41.3	43	0	125	130	0	29	30
2025	11	27	7	1	10	24.9	-2.3	0.941	0.4	0.3	0	41.3	43.4	0	125	130	0	29	29
2025	11	27	7	11	10	24.8	-1.9	0.941	0.3	0.2	0	41.3	43.4	0	125	130	0	29	29
2025	11	27	7	21	10	25.4	-2.4	0.941	0.4	0.3	0	40.9	43	0	125	130	0	30	30
2025	11	27	7	31	10	26.1	-3.1	0.941	0.4	0.3	0	41.3	43.4	0	125	129	0	29	28
2025	11	27	7	41	10	25.2	-2.6	0.941	0.4	0.3	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	7	51	10	24.9	-2.3	0.941	0.4	0.3	0	41.7	42.6	0	125	129	0	28	30

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	27	8	1	10	24.3	-2.4	0.941	0.5	0.4	0	41.3	43	0	125	129	0	29	29
2025	11	27	8	11	10	24.6	-1.5	0.941	0.3	0.2	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	8	21	10	24.7	-2.7	0.941	0.5	0.5	0	41.3	43	0	124	129	0	28	29
2025	11	27	8	31	10	25	-3.5	0.941	0.5	0.4	0	40.9	42.6	0	124	128	0	29	29
2025	11	27	8	41	10	24.9	-2.9	0.941	0.4	0.3	0	40.4	42.6	0	123	128	0	29	29
2025	11	27	8	51	10	24.7	-2.5	0.941	0.4	0.3	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	9	1	10	23.8	-2	0.941	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	9	11	10	24.5	-1.6	0.941	0.4	0.3	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	9	21	10	25.2	-2.4	0.941	0.5	0.4	0	42.6	43.4	0	127	131	0	28	30
2025	11	27	9	31	10	24.1	-2.6	0.941	0.5	0.4	0	42.6	44.3	0	128	133	0	29	30
2025	11	27	9	41	10	25.2	-2.8	0.941	0.4	0.3	0	43.4	45.2	0	130	134	0	29	29
2025	11	27	9	51	10	26	-2.5	0.941	0.4	0.3	0	42.6	44.7	0	128	133	0	29	29
2025	11	27	10	1	10	25.4	-1.3	0.941	0.4	0.3	0	42.6	44.3	0	128	132	0	29	29
2025	11	27	10	11	10	25.3	-2.5	0.941	0.6	0.5	0	42.6	44.3	0	128	133	0	29	30
2025	11	27	10	21	10	24.4	-2.9	0.941	0.5	0.4	0	42.6	43.9	0	127	131	0	28	29
2025	11	27	10	31	10	24.6	-1.8	0.941	0.5	0.4	0	41.3	43.9	0	126	131	0	30	29
2025	11	27	10	41	10	25.2	-2.8	0.941	0.5	0.5	0	42.1	43.9	0	127	131	0	29	29
2025	11	27	10	51	10	25.7	-2.4	0.941	0.5	0.5	0	42.6	44.7	0	128	133	0	29	29
2025	11	27	11	1	10	24.5	-1.6	0.942	0.5	0.5	0	42.6	44.7	0	128	133	0	29	29
2025	11	27	11	11	10	25.4	-1.2	0.941	0.5	0.4	0	42.1	43.4	0	126	131	0	28	30
2025	11	27	11	21	10	23.7	-1.4	0.942	0.4	0.3	0	41.7	43.9	0	126	131	0	29	29
2025	11	27	11	31	10	25.7	-2.4	0.942	0.5	0.4	0	42.1	43.9	0	127	131	0	29	29
2025	11	27	11	41	10	25.1	-2.1	0.942	0.5	0.4	0	42.6	44.7	0	128	133	0	29	29
2025	11	27	11	51	10	25	-2.9	0.942	0.4	0.3	0	45.2	46.9	0	134	138	0	29	29
2025	11	27	12	1	10	25	-1.2	0.942	0.4	0.3	0	46.4	47.7	0	136	140	0	28	29
2025	11	27	12	11	10	25.9	-2.1	0.942	0.5	0.4	0	43.9	44.7	0	130	134	0	28	30
2025	11	27	12	21	10	25.7	-2.8	0.942	0.5	0.4	0	43.9	45.2	0	130	134	0	28	29
2025	11	27	12	31	10	25.7	-2.7	0.942	0.5	0.4	0	45.2	47.3	0	134	139	0	29	29
2025	11	27	12	41	10	25.2	-1.9	0.942	0.5	0.4	0	43	44.7	0	129	133	0	29	29
2025	11	27	12	51	10	24.9	-1.7	0.942	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	13	1	10	25.2	-1.6	0.942	0.5	0.4	0	41.7	43.9	0	126	130	0	29	28
2025	11	27	13	11	10	25.1	-2.2	0.943	0.5	0.5	0	42.1	43.9	0	126	131	0	28	29
2025	11	27	13	21	10	26.1	-2.6	0.943	0.5	0.4	0	42.1	43.4	0	126	130	0	28	29
2025	11	27	13	31	10	24.4	-2.1	0.943	0.3	0.2	0	41.3	43	0	125	129	0	29	29
2025	11	27	13	41	10	24.8	-2.3	0.943	0.5	0.4	0	41.3	43	0	125	129	0	29	29
2025	11	27	13	51	10	24.8	-1.2	0.943	0.3	0.2	0	41.7	43	0	125	129	0	28	29
2025	11	27	14	1	10	24.8	-2.6	0.943	0.5	0.4	0	41.3	42.1	0	124	128	0	28	30
2025	11	27	14	11	10	24.4	-1.9	0.943	0.5	0.5	0	40.9	42.6	0	124	128	0	29	29
2025	11	27	14	21	10	24.9	-2.1	0.943	0.4	0.3	0	40.4	42.1	0	123	127	0	29	29
2025	11	27	14	31	10	25	-2.6	0.943	0.4	0.3	0	40.4	42.1	0	123	127	0	29	29
2025	11	27	14	41	10	24.6	-2.5	0.943	0.5	0.4	0	40.4	42.6	0	123	128	0	29	29
2025	11	27	14	51	10	25.8	-2.8	0.943	0.5	0.4	0	40.9	42.1	0	123	127	0	28	29
2025	11	27	15	1	10	24.9	-2.5	0.943	0.5	0.4	0	40.9	42.6	0	123	128	0	28	29
2025	11	27	15	11	10	24.9	-1.6	0.943	0.4	0.3	0	40.4	42.1	0	123	127	0	29	29
2025	11	27	15	21	10	25	-1.8	0.943	0.5	0.5	0	40.4	42.1	0	123	127	0	29	29
2025	11	27	15	31	10	24.9	-2.3	0.943	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	27	15	41	10	25.6	-2.7	0.943	0.5	0.5	0	40.4	42.1	0	123	127	0	29	29
2025	11	27	15	51	10	24.6	-2.2	0.943	0.5	0.5	0	40.4	42.1	0	123	127	0	29	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	27	16	1	10	25.8	-2.8	0.943	0.3	0.2	0	40.4	42.1	0	123	127	0	29	29
2025	11	27	16	11	10	24.6	-2.1	0.943	0.5	0.4	0	41.3	43	0	124	129	0	28	29
2025	11	27	16	21	10	24.9	-2.1	0.943	0.3	0.2	0	40.9	43	0	124	129	0	29	29
2025	11	27	16	31	10	24.9	-2.3	0.943	0.5	0.5	0	40.9	43	0	124	129	0	29	29
2025	11	27	16	41	10	25.4	-3.3	0.943	0.3	0.2	0	40.9	43	0	123	128	0	28	28
2025	11	27	16	51	10	25.4	-0.9	0.943	0.4	0.3	0	40.4	42.6	0	123	128	0	29	29
2025	11	27	17	1	10	25.1	-3.7	0.943	0.5	0.5	0	40.4	41.7	0	123	127	0	29	30
2025	11	27	17	11	10	25.2	-1.5	0.943	0.5	0.5	0	40.4	42.6	0	123	128	0	29	29
2025	11	27	17	21	10	24.5	-1.9	0.943	0.5	0.4	0	40.9	42.6	0	124	128	0	29	29
2025	11	27	17	31	10	25.5	-2.3	0.943	0.4	0.3	0	41.3	42.6	0	124	128	0	28	29
2025	11	27	17	41	10	24.9	-3.1	0.943	0.5	0.4	0	40.9	42.6	0	123	128	0	28	29
2025	11	27	17	51	10	25.5	-2.9	0.943	0.4	0.3	0	40.4	42.6	0	123	128	0	29	29
2025	11	27	18	1	10	25.4	-2.4	0.943	0.5	0.4	0	40.9	42.6	0	124	128	0	29	29
2025	11	27	18	11	10	26.1	-2.2	0.943	0.4	0.3	0	40.9	43	0	124	128	0	29	28
2025	11	27	18	21	10	26.6	-1.7	0.943	0.5	0.4	0	41.3	43	0	124	129	0	28	29
2025	11	27	18	31	10	25.7	-1.6	0.943	0.5	0.4	0	40.9	43	0	124	129	0	29	29
2025	11	27	18	41	10	25.5	-2.8	0.943	0.4	0.3	0	40.9	43.4	0	124	129	0	29	28
2025	11	27	18	51	10	25.5	-1.8	0.943	0.5	0.4	0	41.7	43.4	0	125	130	0	28	29
2025	11	27	19	1	10	25.1	-2.9	0.943	0.5	0.5	0	41.3	43.4	0	125	129	0	29	28
2025	11	27	19	11	10	24.8	-1.6	0.943	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	27	19	21	10	25.2	-0.5	0.943	0.5	0.4	0	41.7	43.4	0	126	131	0	29	30
2025	11	27	19	31	10	25	-2.5	0.943	0.4	0.3	0	41.3	43.4	0	125	130	0	29	29
2025	11	27	19	41	10	25.7	-3.1	0.943	0.3	0.2	0	41.7	42.6	0	125	129	0	28	30
2025	11	27	19	51	10	25	-1.3	0.943	0.4	0.3	0	41.3	43	0	125	129	0	29	29
2025	11	27	20	1	10	24.5	-2.5	0.943	0.5	0.4	0	40.9	43	0	124	129	0	29	29
2025	11	27	20	11	10	24.9	-1.4	0.943	0.4	0.3	0	40.9	43	0	124	129	0	29	29
2025	11	27	20	21	10	25.4	-1.6	0.943	0.5	0.4	0	41.3	43	0	125	129	0	29	29
2025	11	27	20	31	10	25.2	-2.4	0.943	0.5	0.4	0	40.9	43.4	0	124	129	0	29	28
2025	11	27	20	41	10	25.1	-2.2	0.943	0.4	0.3	0	41.7	43	0	125	129	0	28	29
2025	11	27	20	51	10	24.4	-1.4	0.943	0.4	0.3	0	40.9	43	0	124	129	0	29	29
2025	11	27	21	1	10	25.6	-2.4	0.943	0.5	0.5	0	41.3	43	0	124	129	0	28	29
2025	11	27	21	11	10	26.2	-2.5	0.943	0.4	0.3	0	41.3	43.4	0	124	129	0	28	28
2025	11	27	21	21	10	24.2	-2.5	0.943	0.5	0.4	0	41.7	43	0	125	129	0	28	29
2025	11	27	21	31	10	24.3	-2.9	0.943	0.5	0.4	0	40.9	43	0	124	129	0	29	29
2025	11	27	21	41	10	25.9	-2.9	0.943	0.5	0.4	0	41.3	42.6	0	124	128	0	28	29
2025	11	27	21	51	10	25.2	-2.4	0.943	0.4	0.3	0	41.3	42.6	0	124	128	0	28	29
2025	11	27	22	1	10	25.2	-2.3	0.943	0.3	0.2	0	41.3	43	0	124	129	0	28	29
2025	11	27	22	11	10	24	-1.8	0.943	0.5	0.4	0	41.3	43.4	0	125	130	0	29	29
2025	11	27	22	21	10	24.7	-2	0.943	0.5	0.4	0	40.9	43	0	124	129	0	29	29
2025	11	27	22	31	10	25.5	-2.3	0.942	0.3	0.2	0	40.9	43	0	124	129	0	29	29
2025	11	27	22	41	10	24.3	-1.6	0.943	0.5	0.5	0	40.9	43	0	124	129	0	29	29
2025	11	27	22	51	10	25.1	-2.4	0.943	0.5	0.4	0	40.9	43	0	124	129	0	29	29
2025	11	27	23	1	10	25.7	-2.7	0.943	0.3	0.2	0	40.9	42.6	0	124	128	0	29	29
2025	11	27	23	11	10	25.3	-3.1	0.942	0.5	0.4	0	40.9	42.6	0	124	128	0	29	29
2025	11	27	23	21	10	25.4	-2	0.942	0.5	0.4	0	40.9	43	0	124	129	0	29	29
2025	11	27	23	31	10	26.3	-2.3	0.942	0.5	0.4	0	40.9	43	0	124	129	0	29	29
2025	11	27	23	41	10	24.2	-2.4	0.942	0.5	0.4	0	41.3	43.4	0	124	129	0	28	28
2025	11	27	23	51	10	26	-2.5	0.942	0.5	0.5	0	40.9	43	0	124	129	0	29	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	28	0	1	10	25.1	-1.6	0.942	0.4	0.3	0	41.7	42.6	0	125	129	0	28	30
2025	11	28	0	11	10	25.4	-3	0.942	0.5	0.4	0	40.9	43	0	124	129	0	29	29
2025	11	28	0	21	10	25.3	-2.3	0.942	0.4	0.3	0	40.9	43	0	124	129	0	29	29
2025	11	28	0	31	10	25.9	-2.1	0.942	0.4	0.3	0	41.3	43	0	124	129	0	28	29
2025	11	28	0	41	10	25.6	-3.1	0.942	0.5	0.5	0	41.3	43	0	124	129	0	28	29
2025	11	28	0	51	10	24.7	-1.7	0.942	0.4	0.3	0	40.9	42.6	0	124	128	0	29	29
2025	11	28	1	1	10	26	-1.5	0.942	0.5	0.4	0	40.9	43	0	124	129	0	29	29
2025	11	28	1	11	10	24.7	-1.4	0.942	0.5	0.4	0	40.9	43	0	124	129	0	29	29
2025	11	28	1	21	10	25.2	-2.4	0.942	0.5	0.4	0	41.3	42.6	0	124	129	0	28	30
2025	11	28	1	31	10	24.9	-2.1	0.942	0.4	0.3	0	41.3	43	0	124	129	0	28	29
2025	11	28	1	41	10	24.6	-2.1	0.942	0.4	0.3	0	40.9	43	0	124	129	0	29	29
2025	11	28	1	51	10	25.7	-3.2	0.942	0.5	0.5	0	40.9	42.1	0	124	128	0	29	30
2025	11	28	2	1	10	24.1	-1.1	0.942	0.5	0.4	0	40.9	42.6	0	124	129	0	29	30
2025	11	28	2	11	10	25.1	-2.1	0.942	0.4	0.3	0	41.3	43	0	124	129	0	28	29
2025	11	28	2	21	10	25.6	-2.6	0.941	0.4	0.3	0	40.9	43	0	124	129	0	29	29
2025	11	28	2	31	10	25.9	-2.1	0.941	0.5	0.4	0	40.9	42.6	0	124	128	0	29	29
2025	11	28	2	41	10	25.6	-2.5	0.941	0.5	0.5	0	40.9	42.1	0	123	128	0	28	30
2025	11	28	2	51	10	25.4	-2.8	0.941	0.4	0.3	0	40.9	43	0	124	129	0	29	29
2025	11	28	3	1	10	25.8	-2.4	0.941	0.4	0.3	0	40.9	43	0	124	129	0	29	29
2025	11	28	3	11	10	24.9	-2.8	0.941	0.4	0.3	0	40.9	42.6	0	124	128	0	29	29
2025	11	28	3	21	10	24.7	-3	0.941	0.3	0.2	0	41.3	42.6	0	124	129	0	28	30
2025	11	28	3	31	10	26.6	-3.6	0.942	0.3	0.2	0	40.9	42.1	0	124	128	0	29	30
2025	11	28	3	41	10	24.6	-2.1	0.941	0.4	0.3	0	40.9	42.6	0	124	128	0	29	29
2025	11	28	3	51	10	25.3	-2	0.941	0.4	0.3	0	41.3	43	0	124	129	0	28	29
2025	11	28	4	1	10	24.8	-2.3	0.941	0.4	0.3	0	40.9	43	0	124	129	0	29	29
2025	11	28	4	11	10	25.4	-1.6	0.941	0.5	0.4	0	40.9	42.6	0	123	128	0	28	29
2025	11	28	4	21	10	24.4	-1.5	0.941	0.4	0.3	0	40.9	43	0	124	129	0	29	29
2025	11	28	4	31	10	24.5	-1.7	0.941	0.5	0.4	0	40.4	43	0	124	129	0	30	29
2025	11	28	4	41	10	24.9	-3.4	0.941	0.4	0.3	0	40.4	42.6	0	123	128	0	29	29
2025	11	28	4	51	10	24.9	-1.5	0.941	0.5	0.4	0	40.9	43	0	124	129	0	29	29
2025	11	28	5	1	10	24.4	-2	0.941	0.5	0.4	0	41.3	42.6	0	124	129	0	28	30
2025	11	28	5	11	10	24.8	-2.5	0.941	0.4	0.3	0	40.9	42.1	0	123	128	0	28	30
2025	11	28	5	21	10	25.5	-2.3	0.941	0.5	0.4	0	40.9	43	0	124	129	0	29	29
2025	11	28	5	31	10	25.4	-1.8	0.941	0.5	0.4	0	40.9	43	0	124	129	0	29	29
2025	11	28	5	41	10	25.5	-1.6	0.941	0.5	0.4	0	40.9	43	0	124	129	0	29	29
2025	11	28	5	51	10	24.4	-2.1	0.941	0.3	0.2	0	40.9	42.6	0	124	128	0	29	29
2025	11	28	6	1	10	24.5	-2.4	0.941	0.5	0.4	0	41.3	43	0	125	129	0	29	29
2025	11	28	6	11	10	25.5	-2.8	0.941	0.5	0.4	0	40.9	43	0	124	129	0	29	29
2025	11	28	6	21	10	24.7	-2.4	0.941	0.5	0.5	0	41.3	43	0	124	129	0	28	29
2025	11	28	6	31	10	25.2	-2.4	0.941	0.5	0.4	0	40.4	43	0	124	129	0	30	29
2025	11	28	6	41	10	24.7	-1.9	0.941	0.4	0.3	0	41.3	42.1	0	124	128	0	28	30
2025	11	28	6	51	10	24.1	-1.3	0.941	0.3	0.2	0	40.9	43	0	124	129	0	29	29
2025	11	28	7	1	10	25.1	-2	0.941	0.3	0.2	0	40.4	42.6	0	123	128	0	29	29
2025	11	28	7	11	10	25.8	-3	0.941	0.5	0.5	0	40.9	43	0	124	129	0	29	29
2025	11	28	7	21	10	26.3	-2.4	0.941	0.5	0.4	0	40.4	42.6	0	123	128	0	29	29
2025	11	28	7	31	10	25.2	-3.1	0.941	0.4	0.3	0	40	42.6	0	123	128	0	30	29
2025	11	28	7	41	10	25.8	-2.2	0.941	0.4	0.3	0	41.7	43.4	0	125	130	0	28	29
2025	11	28	7	51	10	24.3	-1.6	0.941	0.5	0.4	0	40.9	42.6	0	124	129	0	29	30

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	28	8	1	10	25	-2	0.941	0.4	0.3	0	40	41.7	0	122	127	0	29	30
2025	11	28	8	11	10	25.8	-1.9	0.941	0.5	0.4	0	40.4	41.7	0	123	127	0	29	30
2025	11	28	8	21	10	24.7	-3	0.941	0.4	0.3	0	40.4	41.7	0	122	127	0	28	30
2025	11	28	8	31	10	24.8	-2.5	0.941	0.5	0.4	0	40.4	41.7	0	123	127	0	29	30
2025	11	28	8	41	10	23.8	-1.3	0.941	0.5	0.4	0	40.4	42.1	0	123	128	0	29	30
2025	11	28	8	51	10	25.2	-2.6	0.941	0.4	0.3	0	40.4	42.1	0	123	127	0	29	29
2025	11	28	9	1	10	24.7	-1.3	0.941	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	28	9	11	10	24.3	-1.3	0.941	0.5	0.4	0	39.6	41.7	0	122	127	0	30	30
2025	11	28	9	21	10	25.3	-2.7	0.941	0.5	0.4	0	40	41.3	0	122	126	0	29	30
2025	11	28	9	31	10	26	-1.5	0.941	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	28	9	41	10	24.5	-1.9	0.941	0.5	0.4	0	40.4	42.1	0	123	128	0	29	30
2025	11	28	9	51	10	25.9	-2.7	0.941	0.4	0.3	0	40.4	42.1	0	123	128	0	29	30
2025	11	28	10	1	10	25.2	-2.2	0.941	0.5	0.5	0	40.4	42.1	0	123	128	0	29	30
2025	11	28	10	11	10	24.6	-1.3	0.941	0.3	0.2	0	40.9	42.6	0	124	128	0	29	29
2025	11	28	10	21	10	25.5	-3	0.941	0.5	0.4	0	40.9	42.1	0	124	128	0	29	30
2025	11	28	10	31	10	24.7	-2	0.941	0.5	0.4	0	40.4	41.7	0	123	127	0	29	30
2025	11	28	10	41	10	25.5	-1.6	0.941	0.5	0.4	0	40.4	42.1	0	123	127	0	29	29
2025	11	28	10	51	10	24.4	-1.6	0.941	0.5	0.4	0	40.4	42.1	0	123	127	0	29	29
2025	11	28	11	1	10	25.2	-2.5	0.941	0.5	0.5	0	40.4	41.7	0	123	127	0	29	30
2025	11	28	11	11	10	25.5	-2.8	0.941	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	28	11	21	10	24.6	-1.8	0.941	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	28	11	31	10	25.8	-2.4	0.941	0.5	0.4	0	39.6	41.7	0	121	126	0	29	29
2025	11	28	11	41	10	23.6	-2.2	0.941	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	28	11	51	10	24.8	-2.6	0.941	0.5	0.4	0	40	41.7	0	121	126	0	28	29
2025	11	28	12	1	10	25.3	-2.4	0.941	0.4	0.3	0	39.6	41.7	0	121	126	0	29	29
2025	11	28	12	11	10	25.6	-2	0.941	0.5	0.5	0	39.1	41.3	0	121	125	0	30	29
2025	11	28	12	21	10	24.7	-3.2	0.941	0.5	0.5	0	39.6	41.3	0	121	125	0	29	29
2025	11	28	12	31	10	25.6	-2.6	0.942	0.5	0.4	0	40	41.3	0	121	125	0	28	29
2025	11	28	12	41	10	25.4	-0.9	0.942	0.4	0.3	0	39.6	41.7	0	121	126	0	29	29
2025	11	28	12	51	10	25.5	-1.9	0.942	0.5	0.4	0	39.6	41.7	0	121	126	0	29	29
2025	11	28	13	1	10	24.4	-2	0.942	0.3	0.2	0	39.6	40.9	0	121	125	0	29	30
2025	11	28	13	11	10	26.3	-2.8	0.942	0.5	0.4	0	40	41.3	0	121	125	0	28	29
2025	11	28	13	21	10	26.2	-2.5	0.942	0.4	0.3	0	40	41.7	0	121	126	0	28	29
2025	11	28	13	31	10	25.5	-2.4	0.942	0.3	0.2	0	39.6	41.7	0	121	126	0	29	29
2025	11	28	13	41	10	25.5	-1.2	0.942	0.4	0.3	0	40	41.7	0	122	126	0	29	29
2025	11	28	13	51	10	24.7	-2.3	0.942	0.4	0.3	0	40.4	42.1	0	122	127	0	28	29
2025	11	28	14	1	10	24.7	-2.6	0.942	0.4	0.3	0	40.9	42.1	0	123	127	0	28	29
2025	11	28	14	11	10	25.2	-2.5	0.942	0.5	0.5	0	40	42.1	0	122	127	0	29	29
2025	11	28	14	21	10	25.2	-2.1	0.942	0.5	0.4	0	40.4	41.7	0	122	126	0	28	29
2025	11	28	14	31	10	25	-2	0.942	0.5	0.4	0	40	41.7	0	122	126	0	29	29
2025	11	28	14	41	10	25	-2.3	0.942	0.5	0.4	0	40	41.7	0	122	126	0	29	29
2025	11	28	14	51	10	24.9	-2.5	0.942	0.4	0.3	0	40	41.3	0	122	126	0	29	30
2025	11	28	15	1	10	25.4	-1.6	0.943	0.5	0.5	0	40	41.3	0	122	126	0	29	30
2025	11	28	15	11	10	25.7	-1.7	0.943	0.4	0.3	0	40	41.7	0	122	126	0	29	29
2025	11	28	15	21	10	25.9	-2.5	0.942	0.4	0.3	0	40	41.7	0	121	126	0	28	29
2025	11	28	15	31	10	26.6	-2.2	0.943	0.4	0.3	0	39.6	41.7	0	121	126	0	29	29
2025	11	28	15	41	10	25.1	-1.4	0.943	0.4	0.3	0	39.6	41.3	0	121	125	0	29	29
2025	11	28	15	51	10	25.6	-1.7	0.943	0.4	0.3	0	40	41.3	0	121	125	0	28	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	28	16	1	10	24.9	-1.9	0.943	0.4	0.3	0	39.6	41.3	0	121	125	0	29	29
2025	11	28	16	11	10	26.5	-2	0.943	0.4	0.3	0	39.6	41.3	0	121	125	0	29	29
2025	11	28	16	21	10	25.3	-3.4	0.943	0.4	0.3	0	39.6	41.3	0	121	125	0	29	29
2025	11	28	16	31	10	26.2	-2.3	0.943	0.5	0.4	0	40	42.1	0	122	126	0	29	28
2025	11	28	16	41	10	25.1	-2.1	0.943	0.4	0.3	0	40	41.7	0	122	126	0	29	29
2025	11	28	16	51	10	25	-2	0.943	0.4	0.3	0	40	42.1	0	122	126	0	29	28
2025	11	28	17	1	10	26.4	-1.6	0.943	0.4	0.3	0	40	41.7	0	121	126	0	28	29
2025	11	28	17	11	10	24.2	-2.9	0.943	0.4	0.3	0	40.4	42.1	0	122	127	0	28	29
2025	11	28	17	21	10	25.3	-3	0.943	0.4	0.3	0	40	41.7	0	122	126	0	29	29
2025	11	28	17	31	10	25	-3	0.943	0.5	0.4	0	40	41.7	0	122	126	0	29	29
2025	11	28	17	41	10	26.4	-1.9	0.943	0.6	0.5	0	40	42.1	0	121	126	0	28	28
2025	11	28	17	51	10	25.3	-2.2	0.943	0.4	0.3	0	40.4	42.1	0	122	127	0	28	29
2025	11	28	18	1	10	25.4	-2.9	0.943	0.5	0.4	0	39.6	41.7	0	121	126	0	29	29
2025	11	28	18	11	10	24.8	-2.9	0.943	0.4	0.3	0	40	42.6	0	122	127	0	29	28
2025	11	28	18	21	10	25.5	-1.8	0.943	0.5	0.4	0	40.9	42.1	0	123	127	0	28	29
2025	11	28	18	31	10	25.4	-2.6	0.943	0.5	0.5	0	40.9	42.1	0	123	127	0	28	29
2025	11	28	18	41	10	25.3	-1.7	0.943	0.5	0.4	0	41.3	43.4	0	125	130	0	29	29
2025	11	28	18	51	10	25.7	-3	0.943	0.5	0.4	0	41.7	43.9	0	126	131	0	29	29
2025	11	28	19	1	10	24.7	-1.8	0.943	0.5	0.4	0	42.1	43.4	0	126	130	0	28	29
2025	11	28	19	11	10	24.2	-1.8	0.943	0.3	0.2	0	41.3	43	0	125	129	0	29	29
2025	11	28	19	21	10	24.3	-1.7	0.943	0.5	0.4	0	41.7	43	0	125	129	0	28	29
2025	11	28	19	31	10	25.7	-1.3	0.943	0.4	0.3	0	40.9	42.6	0	124	129	0	29	30
2025	11	28	19	41	10	25.3	-2.1	0.943	0.5	0.4	0	41.3	43	0	125	129	0	29	29
2025	11	28	19	51	10	25.4	-2.7	0.943	0.4	0.3	0	41.3	42.6	0	124	128	0	28	29
2025	11	28	20	1	10	25.3	-2.6	0.943	0.5	0.4	0	40.4	42.1	0	123	127	0	29	29
2025	11	28	20	11	10	26	-2.3	0.943	0.5	0.4	0	40.4	42.6	0	123	128	0	29	29
2025	11	28	20	21	10	25.1	-2.4	0.943	0.3	0.2	0	40.9	42.6	0	124	128	0	29	29
2025	11	28	20	31	10	24.9	-1.6	0.943	0.5	0.4	0	40.9	42.6	0	123	128	0	28	29
2025	11	28	20	41	10	24.7	-1.8	0.943	0.4	0.3	0	40.4	42.6	0	123	128	0	29	29
2025	11	28	20	51	10	24.4	-1.3	0.943	0.4	0.3	0	40.4	42.6	0	123	128	0	29	29
2025	11	28	21	1	10	24.1	-2.7	0.943	0.3	0.2	0	40.9	42.6	0	123	128	0	28	29
2025	11	28	21	11	10	24.4	-2.7	0.943	0.4	0.3	0	40.4	42.6	0	123	128	0	29	29
2025	11	28	21	21	10	24.8	-1.2	0.942	0.4	0.3	0	40.4	43	0	123	128	0	29	28
2025	11	28	21	31	10	24.9	-3	0.943	0.3	0.2	0	40.4	42.6	0	123	128	0	29	29
2025	11	28	21	41	10	24.4	-1.7	0.943	0.5	0.4	0	40.9	43	0	123	128	0	28	28
2025	11	28	21	51	10	25.6	-2.8	0.943	0.6	0.5	0	40.4	42.6	0	123	127	0	29	28
2025	11	28	22	1	10	26.1	-2.8	0.942	0.4	0.3	0	40.4	42.1	0	123	127	0	29	29
2025	11	28	22	11	10	26	-2.4	0.942	0.4	0.3	0	40.4	42.6	0	123	128	0	29	29
2025	11	28	22	21	10	25.6	-1	0.943	0.4	0.3	0	40.4	42.1	0	122	127	0	28	29
2025	11	28	22	31	10	24.3	-1.6	0.942	0.4	0.3	0	40.4	42.1	0	123	127	0	29	29
2025	11	28	22	41	10	25.6	-3.1	0.942	0.5	0.4	0	40.4	42.1	0	122	128	0	28	30
2025	11	28	22	51	10	25.2	-1.2	0.942	0.5	0.4	0	40.9	42.6	0	123	128	0	28	29
2025	11	28	23	1	10	25.1	-1.6	0.942	0.4	0.3	0	40.4	42.6	0	123	128	0	29	29
2025	11	28	23	11	10	24.7	-1.8	0.942	0.4	0.3	0	40.9	42.6	0	123	128	0	28	29
2025	11	28	23	21	10	24.9	-2	0.942	0.4	0.3	0	40.4	42.1	0	122	127	0	28	29
2025	11	28	23	31	10	25.8	-1.8	0.942	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	28	23	41	10	24.7	-1.9	0.942	0.5	0.4	0	40.9	41.7	0	123	127	0	28	30
2025	11	28	23	51	10	25.6	-1.5	0.942	0.5	0.4	0	40.4	42.6	0	122	127	0	28	28

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	29	0	1	10	24.3	-1.5	0.942	0.5	0.4	0	40.4	42.1	0	123	127	0	29	29
2025	11	29	0	11	10	25.5	-2	0.942	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	29	0	21	10	23.8	-1.2	0.942	0.5	0.5	0	40.9	43	0	124	129	0	29	29
2025	11	29	0	31	10	25.1	-2.3	0.942	0.5	0.4	0	40.4	42.6	0	123	128	0	29	29
2025	11	29	0	41	10	25.1	-2.8	0.942	0.6	0.5	0	40	42.1	0	122	127	0	29	29
2025	11	29	0	51	10	25.8	-2.7	0.941	0.4	0.3	0	40.4	42.1	0	122	127	0	28	29
2025	11	29	1	1	10	24.6	-2.9	0.942	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	29	1	11	10	24.6	-2	0.941	0.5	0.4	0	40	41.7	0	122	127	0	29	30
2025	11	29	1	21	10	25.8	-1.6	0.941	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	29	1	31	10	26.5	-2.2	0.941	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	29	1	41	10	26.2	-2.4	0.941	0.4	0.3	0	40.4	42.1	0	122	127	0	28	29
2025	11	29	1	51	10	25.7	-2.7	0.941	0.5	0.4	0	40	41.7	0	122	126	0	29	29
2025	11	29	2	1	10	26.1	-2.4	0.941	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	29	2	11	10	24.9	-1.5	0.941	0.4	0.3	0	40.4	42.1	0	122	127	0	28	29
2025	11	29	2	21	10	25.7	-1.7	0.941	0.3	0.2	0	40	42.1	0	122	127	0	29	29
2025	11	29	2	31	10	25.7	-2.1	0.941	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	29	2	41	10	24.5	-2.8	0.941	0.5	0.4	0	40	42.6	0	122	128	0	29	29
2025	11	29	2	51	10	26.8	-2.7	0.941	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	29	3	1	10	26.1	-2.7	0.941	0.4	0.3	0	40	41.7	0	122	127	0	29	30
2025	11	29	3	11	10	25	-1.1	0.941	0.5	0.4	0	40.4	41.7	0	122	127	0	28	30
2025	11	29	3	21	10	25.5	-2.7	0.941	0.4	0.3	0	40.4	42.1	0	122	127	0	28	29
2025	11	29	3	31	10	24.3	-1.8	0.941	0.5	0.5	0	40	42.1	0	122	127	0	29	29
2025	11	29	3	41	10	25.3	-1.6	0.941	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	29	3	51	10	25.7	-2	0.941	0.5	0.5	0	40	42.1	0	122	127	0	29	29
2025	11	29	4	1	10	25.4	-3.6	0.941	0.5	0.4	0	40	41.7	0	122	127	0	29	30
2025	11	29	4	11	10	24.9	-1.8	0.941	0.3	0.2	0	40	42.1	0	122	127	0	29	29
2025	11	29	4	21	10	25.4	-2.4	0.941	0.5	0.4	0	40.4	42.6	0	123	128	0	29	29
2025	11	29	4	31	10	25.7	-2	0.941	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	29	4	41	10	24.8	-2	0.941	0.5	0.4	0	40.9	43	0	124	129	0	29	29
2025	11	29	4	51	10	24.8	-2.8	0.94	0.5	0.4	0	40	42.6	0	123	128	0	30	29
2025	11	29	5	1	10	24.9	-2.6	0.94	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	29	5	11	10	25	-2.5	0.941	0.3	0.2	0	40.4	42.6	0	123	128	0	29	29
2025	11	29	5	21	10	24.8	-2.4	0.94	0.5	0.5	0	40.9	42.6	0	123	128	0	28	29
2025	11	29	5	31	10	24.3	-3.3	0.941	0.3	0.2	0	40	41.7	0	122	127	0	29	30
2025	11	29	5	41	10	25	-2	0.94	0.5	0.4	0	40.4	42.6	0	123	128	0	29	29
2025	11	29	5	51	10	24.6	-1.6	0.94	0.5	0.4	0	40	41.7	0	122	127	0	29	30
2025	11	29	6	1	10	25	-2.7	0.94	0.4	0.3	0	40.4	42.6	0	123	128	0	29	29
2025	11	29	6	11	10	24.3	-1.6	0.941	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	29	6	21	10	25.6	-2.5	0.94	0.3	0.2	0	40	42.6	0	122	128	0	29	29
2025	11	29	6	31	10	26.2	-2.6	0.94	0.4	0.3	0	39.6	41.7	0	121	127	0	29	30
2025	11	29	6	41	10	25.1	-3	0.94	0.4	0.3	0	39.6	41.7	0	121	126	0	29	29
2025	11	29	6	51	10	24.3	-1.3	0.94	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	29	7	1	10	24.6	-2.1	0.94	0.5	0.4	0	40	41.7	0	122	127	0	29	30
2025	11	29	7	11	10	24.3	-2.3	0.94	0.5	0.4	0	40	41.7	0	122	127	0	29	30
2025	11	29	7	21	10	25.2	-1.5	0.94	0.5	0.4	0	40	42.6	0	122	128	0	29	29
2025	11	29	7	31	10	25	-2	0.94	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	29	7	41	10	24.6	-2.3	0.94	0.5	0.4	0	40	41.7	0	122	127	0	29	30
2025	11	29	7	51	10	25	-2.8	0.94	0.5	0.5	0	39.6	41.7	0	121	127	0	29	30

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	29	8	1	10	25.2	-2.6	0.94	0.6	0.5	0	40	41.3	0	121	126	0	28	30
2025	11	29	8	11	10	25	-2.4	0.94	0.4	0.3	0	39.1	41.3	0	120	125	0	29	29
2025	11	29	8	21	10	24.7	-2.1	0.94	0.4	0.3	0	39.1	41.3	0	120	125	0	29	29
2025	11	29	8	31	10	24.7	-2.6	0.94	0.5	0.4	0	40	42.6	0	122	128	0	29	29
2025	11	29	8	41	10	25.5	-2.7	0.94	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	29	8	51	10	26.2	-2.3	0.94	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	29	9	1	10	25.2	-2.3	0.94	0.4	0.3	0	39.1	41.7	0	120	126	0	29	29
2025	11	29	9	11	10	24.5	-2.2	0.94	0.5	0.4	0	39.6	41.7	0	121	126	0	29	29
2025	11	29	9	21	10	25.5	-2.5	0.94	0.5	0.4	0	39.1	40.9	0	120	125	0	29	30
2025	11	29	9	31	10	25.1	-2.1	0.94	0.3	0.2	0	39.1	41.3	0	120	125	0	29	29
2025	11	29	9	41	10	25.5	-1.7	0.94	0.4	0.3	0	39.1	40.9	0	120	125	0	29	30
2025	11	29	9	51	10	24.3	-3.3	0.94	0.3	0.2	0	38.7	41.3	0	119	125	0	29	29
2025	11	29	10	1	10	25.8	-2.5	0.94	0.5	0.4	0	38.7	40.9	0	119	124	0	29	29
2025	11	29	10	11	10	25	-3.2	0.94	0.5	0.4	0	38.7	40.9	0	119	124	0	29	29
2025	11	29	10	21	10	24.8	-2.1	0.941	0.5	0.5	0	38.7	40.9	0	119	124	0	29	29
2025	11	29	10	31	10	24.1	-2	0.94	0.4	0.3	0	39.1	40.9	0	119	124	0	28	29
2025	11	29	10	41	10	24.7	-2.8	0.941	0.3	0.2	0	38.7	40.9	0	119	124	0	29	29
2025	11	29	10	51	10	24.4	-1.6	0.941	0.4	0.3	0	40	41.7	0	121	126	0	28	29
2025	11	29	11	1	10	24.5	-1.4	0.941	0.5	0.5	0	39.1	41.7	0	120	126	0	29	29
2025	11	29	11	11	10	24.9	-1.6	0.941	0.4	0.3	0	39.1	41.3	0	120	125	0	29	29
2025	11	29	11	21	10	24.5	-2	0.941	0.5	0.4	0	38.3	40.4	0	118	123	0	29	29
2025	11	29	11	31	10	24.6	-2.8	0.941	0.5	0.5	0	38.3	40	0	118	122	0	29	29
2025	11	29	11	41	10	24.5	-2.8	0.941	0.5	0.4	0	38.7	40	0	118	122	0	28	29
2025	11	29	11	51	10	25.1	-3.1	0.941	0.5	0.4	0	39.6	40.9	0	120	125	0	28	30
2025	11	29	12	1	10	25.4	-2.8	0.941	0.5	0.4	0	40	41.3	0	121	125	0	28	29
2025	11	29	12	11	10	24.5	-1.4	0.941	0.5	0.4	0	40	41.7	0	122	127	0	29	30
2025	11	29	12	21	10	24.8	-2.3	0.941	0.5	0.5	0	40.9	43	0	124	129	0	29	29
2025	11	29	12	31	10	24.4	-2	0.941	0.4	0.3	0	41.3	43	0	124	129	0	28	29
2025	11	29	12	41	10	25	-1.6	0.941	0.5	0.5	0	39.6	42.1	0	121	127	0	29	29
2025	11	29	12	51	10	24.2	-3	0.942	0.5	0.4	0	39.6	41.7	0	121	126	0	29	29
2025	11	29	13	1	10	25	-1.8	0.941	0.5	0.4	0	40	41.7	0	121	126	0	28	29
2025	11	29	13	11	10	25.5	-2.8	0.942	0.5	0.5	0	40.4	42.6	0	123	128	0	29	29
2025	11	29	13	21	10	25.6	-1.3	0.942	0.4	0.3	0	41.3	43.4	0	124	130	0	28	29
2025	11	29	13	31	10	25.9	-2.7	0.942	0.5	0.4	0	41.7	43.9	0	126	131	0	29	29
2025	11	29	13	41	10	24.1	-3	0.942	0.5	0.4	0	41.7	43.4	0	126	130	0	29	29
2025	11	29	13	51	10	25.2	-1.6	0.942	0.5	0.5	0	41.3	43.4	0	125	130	0	29	29
2025	11	29	14	1	10	25.2	-1.6	0.942	0.5	0.4	0	40.9	42.6	0	123	128	0	28	29
2025	11	29	14	11	10	25.6	-1	0.942	0.5	0.4	0	40.9	43	0	123	128	0	28	28
2025	11	29	14	21	10	24.5	-1.2	0.942	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	29	14	31	10	24.4	-2.5	0.942	0.5	0.5	0	40.9	43	0	124	129	0	29	29
2025	11	29	14	41	10	25.4	-2.4	0.942	0.5	0.4	0	42.1	44.3	0	126	131	0	28	28
2025	11	29	14	51	10	26	-2.2	0.942	0.6	0.5	0	42.6	44.3	0	127	132	0	28	29
2025	11	29	15	1	10	26.2	-2.5	0.942	0.5	0.4	0	42.1	44.3	0	127	132	0	29	29
2025	11	29	15	11	10	24.9	-1.7	0.942	0.4	0.3	0	41.7	43.9	0	126	131	0	29	29
2025	11	29	15	21	10	25.1	-2.1	0.942	0.3	0.2	0	42.6	44.7	0	128	133	0	29	29
2025	11	29	15	31	10	26.2	-2	0.942	0.4	0.3	0	43.9	46	0	131	135	0	29	28
2025	11	29	15	41	10	25.1	-2.2	0.942	0.4	0.3	0	43.4	46	0	130	135	0	29	28
2025	11	29	15	51	10	25.3	-2.1	0.942	0.5	0.4	0	42.1	44.3	0	127	132	0	29	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	29	16	1	10	24.9	-2.2	0.942	0.5	0.5	0	42.1	43.9	0	126	131	0	28	29
2025	11	29	16	11	10	25.4	-1.7	0.942	0.5	0.5	0	41.7	43.9	0	126	131	0	29	29
2025	11	29	16	21	10	25.4	-1.9	0.942	0.4	0.3	0	41.3	43.4	0	125	130	0	29	29
2025	11	29	16	31	10	24.9	-2.1	0.943	0.5	0.4	0	41.3	43	0	124	129	0	28	29
2025	11	29	16	41	10	25.6	-2.4	0.943	0.5	0.4	0	40.9	42.6	0	124	129	0	29	30
2025	11	29	16	51	10	25.6	-2.7	0.942	0.5	0.5	0	43.9	45.6	0	130	135	0	28	29
2025	11	29	17	1	10	25.3	-1.1	0.943	0.4	0.3	0	43	45.2	0	130	135	0	30	30
2025	11	29	17	11	10	25.1	-1.4	0.943	0.3	0.2	0	43	44.7	0	129	134	0	29	30
2025	11	29	17	21	10	25.9	-1.7	0.943	0.4	0.3	0	42.1	44.7	0	126	132	0	28	28
2025	11	29	17	31	10	25.3	-1.8	0.943	0.5	0.4	0	41.7	43.4	0	125	130	0	28	29
2025	11	29	17	41	10	24.5	-1.2	0.943	0.4	0.3	0	40.9	43	0	123	129	0	28	29
2025	11	29	17	51	10	25.8	-2.9	0.943	0.5	0.4	0	40.9	42.1	0	123	128	0	28	30
2025	11	29	18	1	10	25.3	-1.6	0.943	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	29	18	11	10	25.4	-2.2	0.943	0.5	0.5	0	40	42.1	0	122	127	0	29	29
2025	11	29	18	21	10	24.8	-1.8	0.943	0.5	0.4	0	40.9	43	0	123	129	0	28	29
2025	11	29	18	31	10	24.9	-2.2	0.943	0.5	0.5	0	40.4	42.6	0	123	128	0	29	29
2025	11	29	18	41	10	25.7	-2.5	0.943	0.4	0.3	0	40.4	42.1	0	123	128	0	29	30
2025	11	29	18	51	10	26.4	-2.8	0.943	0.3	0.2	0	40	42.6	0	122	128	0	29	29
2025	11	29	19	1	10	24.4	-1.9	0.943	0.6	0.5	0	40.4	42.6	0	123	128	0	29	29
2025	11	29	19	11	10	25.2	-2.4	0.943	0.5	0.5	0	40.9	42.6	0	123	128	0	28	29
2025	11	29	19	21	10	25.3	-2.1	0.943	0.5	0.5	0	40.4	42.6	0	123	128	0	29	29
2025	11	29	19	31	10	26.4	-1.9	0.943	0.5	0.5	0	40.9	42.6	0	123	128	0	28	29
2025	11	29	19	41	10	24.3	-1.6	0.943	0.5	0.4	0	40.4	42.1	0	123	128	0	29	30
2025	11	29	19	51	10	25.7	-2.5	0.943	0.4	0.3	0	40.4	42.6	0	122	127	0	28	28
2025	11	29	20	1	10	25.3	-3.3	0.943	0.5	0.4	0	40	42.6	0	122	128	0	29	29
2025	11	29	20	11	10	25.2	-2.2	0.943	0.5	0.4	0	40.9	43	0	123	128	0	28	28
2025	11	29	20	21	10	25.3	-1.8	0.943	0.4	0.3	0	40	42.6	0	122	128	0	29	29
2025	11	29	20	31	10	24.2	-1.8	0.943	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	29	20	41	10	25.6	-3.2	0.943	0.4	0.3	0	40.4	42.1	0	122	127	0	28	29
2025	11	29	20	51	10	25.4	-1.9	0.943	0.5	0.4	0	40.4	42.1	0	122	127	0	28	29
2025	11	29	21	1	10	25.1	-3.2	0.943	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	29	21	11	10	25.5	-2.4	0.943	0.4	0.3	0	40.4	43	0	123	129	0	29	29
2025	11	29	21	21	10	25.9	-2.4	0.943	0.4	0.3	0	40.4	42.6	0	123	128	0	29	29
2025	11	29	21	31	10	24.4	-2.7	0.943	0.5	0.4	0	40.9	43	0	124	129	0	29	29
2025	11	29	21	41	10	25.4	-2.1	0.943	0.3	0.2	0	41.3	42.6	0	124	129	0	28	30
2025	11	29	21	51	10	26.1	-2.3	0.943	0.4	0.3	0	40.9	43.4	0	124	130	0	29	29
2025	11	29	22	1	10	25.3	-2	0.943	0.5	0.5	0	41.3	43.4	0	125	130	0	29	29
2025	11	29	22	11	10	25.1	-1.8	0.943	0.4	0.3	0	40.9	43	0	123	128	0	28	28
2025	11	29	22	21	10	25	-2.7	0.943	0.5	0.5	0	40.4	42.6	0	123	128	0	29	29
2025	11	29	22	31	10	25.3	-2	0.943	0.3	0.2	0	40.4	42.6	0	122	128	0	28	29
2025	11	29	22	41	10	25.5	-2.2	0.942	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	29	22	51	10	25.4	-2	0.942	0.4	0.3	0	40	42.6	0	122	128	0	29	29
2025	11	29	23	1	10	25.7	-2.8	0.942	0.5	0.4	0	40.4	42.1	0	122	127	0	28	29
2025	11	29	23	11	10	26	-1.7	0.942	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	29	23	21	10	24.3	-2	0.942	0.5	0.4	0	40	42.6	0	122	128	0	29	29
2025	11	29	23	31	10	26.8	-1.4	0.942	0.5	0.4	0	39.6	42.1	0	121	127	0	29	29
2025	11	29	23	41	10	25.1	-2.3	0.942	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	29	23	51	10	25.4	-1.7	0.942	0.4	0.3	0	40	42.1	0	122	127	0	29	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	30	0	1	10	25.5	-2.8	0.942	0.5	0.4	0	40.4	42.1	0	122	127	0	28	29
2025	11	30	0	11	10	25.5	-1.6	0.942	0.3	0.2	0	40	42.1	0	122	127	0	29	29
2025	11	30	0	21	10	24.6	-2.4	0.942	0.4	0.3	0	40	41.7	0	121	127	0	28	30
2025	11	30	0	31	10	25.9	-1.8	0.942	0.5	0.4	0	40	42.6	0	121	127	0	28	28
2025	11	30	0	41	10	25.6	-1.8	0.942	0.5	0.5	0	40	42.1	0	122	127	0	29	29
2025	11	30	0	51	10	25.3	-2.5	0.942	0.4	0.3	0	40	41.7	0	121	126	0	28	29
2025	11	30	1	1	10	24.7	-2.7	0.942	0.4	0.3	0	39.6	42.1	0	121	127	0	29	29
2025	11	30	1	11	10	24.8	-2.1	0.942	0.5	0.4	0	39.6	42.1	0	121	127	0	29	29
2025	11	30	1	21	10	25.6	-2.3	0.942	0.5	0.4	0	39.6	42.1	0	121	127	0	29	29
2025	11	30	1	31	10	25.2	-2.3	0.941	0.4	0.3	0	40	42.6	0	122	128	0	29	29
2025	11	30	1	41	10	25.6	-2.7	0.941	0.6	0.5	0	40	42.1	0	122	127	0	29	29
2025	11	30	1	51	10	25	-1.6	0.941	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	30	2	1	10	25.3	-1.4	0.941	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	30	2	11	10	25.8	-1.7	0.941	0.5	0.4	0	39.6	41.7	0	121	126	0	29	29
2025	11	30	2	21	10	24.9	-2.8	0.941	0.4	0.3	0	39.6	42.1	0	121	127	0	29	29
2025	11	30	2	31	10	25.2	-1.7	0.941	0.5	0.4	0	40	42.6	0	122	127	0	29	28
2025	11	30	2	41	10	25.7	-2	0.941	0.5	0.4	0	39.6	42.1	0	121	127	0	29	29
2025	11	30	2	51	10	24.2	-1.7	0.941	0.5	0.4	0	40	41.7	0	122	127	0	29	30
2025	11	30	3	1	10	25.4	-2.1	0.941	0.4	0.3	0	39.6	42.1	0	121	127	0	29	29
2025	11	30	3	11	10	25.2	-1.1	0.941	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	30	3	21	10	24.9	-3.6	0.941	0.5	0.4	0	39.6	42.1	0	121	127	0	29	29
2025	11	30	3	31	10	25.6	-1.9	0.941	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	30	3	41	10	24.8	-2.5	0.941	0.6	0.5	0	39.6	42.1	0	121	127	0	29	29
2025	11	30	3	51	10	25.1	-1.9	0.941	0.5	0.4	0	39.6	41.7	0	121	126	0	29	29
2025	11	30	4	1	10	25.4	-2.9	0.941	0.5	0.4	0	39.6	41.7	0	121	127	0	29	30
2025	11	30	4	11	10	24.9	-2	0.94	0.4	0.3	0	40	42.1	0	121	127	0	28	29
2025	11	30	4	21	10	25.9	-2.9	0.941	0.5	0.5	0	39.6	42.1	0	121	127	0	29	29
2025	11	30	4	31	10	24.8	-1.6	0.94	0.5	0.5	0	40	42.1	0	122	127	0	29	29
2025	11	30	4	41	10	25.8	-3.5	0.94	0.5	0.4	0	39.6	41.7	0	121	127	0	29	30
2025	11	30	4	51	10	24.9	-3.1	0.94	0.3	0.2	0	40	42.1	0	122	127	0	29	29
2025	11	30	5	1	10	24.6	-1.8	0.94	0.4	0.3	0	39.6	41.3	0	121	126	0	29	30
2025	11	30	5	11	10	24.8	-2.8	0.94	0.4	0.3	0	40	41.7	0	121	127	0	28	30
2025	11	30	5	21	10	24.2	-2	0.94	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	30	5	31	10	25	-2.2	0.94	0.6	0.5	0	40	42.1	0	122	127	0	29	29
2025	11	30	5	41	10	26.1	-1.9	0.94	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	30	5	51	10	25.2	-1.8	0.94	0.4	0.3	0	40	42.1	0	122	127	0	29	29
2025	11	30	6	1	10	25.1	-3	0.94	0.3	0.2	0	40	42.1	0	122	127	0	29	29
2025	11	30	6	11	10	24.8	-3.2	0.94	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	30	6	21	10	25.1	-1.4	0.94	0.5	0.4	0	40.4	42.1	0	122	127	0	28	29
2025	11	30	6	31	10	24.8	-3	0.94	0.5	0.5	0	40	41.7	0	122	127	0	29	30
2025	11	30	6	41	10	24.4	-1.6	0.94	0.5	0.4	0	40.4	42.1	0	122	127	0	28	29
2025	11	30	6	51	10	26.2	-3.1	0.94	0.5	0.4	0	39.6	42.1	0	121	127	0	29	29
2025	11	30	7	1	10	25.4	-2.8	0.94	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	30	7	11	10	25.2	-2.6	0.94	0.4	0.3	0	39.6	42.1	0	121	127	0	29	29
2025	11	30	7	21	10	24.1	-2.1	0.94	0.4	0.3	0	39.6	42.1	0	122	127	0	30	29
2025	11	30	7	31	10	25.8	-2.5	0.94	0.5	0.4	0	40	41.7	0	122	127	0	29	30
2025	11	30	7	41	10	25.4	-2.5	0.94	0.4	0.3	0	39.6	41.7	0	121	127	0	29	30
2025	11	30	7	51	10	24.6	-2.7	0.94	0.4	0.3	0	40.4	42.6	0	123	129	0	29	30

Mazourka (0354)																			
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	30	8	1	10	24.3	-2	0.94	0.4	0.3	0	40.9	43	0	124	129	0	29	29
2025	11	30	8	11	10	24.9	-2.4	0.94	0.4	0.3	0	40.9	42.6	0	124	129	0	29	30
2025	11	30	8	21	10	24.1	-2.3	0.94	0.4	0.3	0	40.4	43	0	124	129	0	30	29
2025	11	30	8	31	10	25.7	-2.6	0.94	0.5	0.4	0	40.4	42.6	0	123	128	0	29	29
2025	11	30	8	41	10	25.2	-2	0.94	0.3	0.2	0	40.4	42.6	0	123	128	0	29	29
2025	11	30	8	51	10	25.9	-1.7	0.94	0.4	0.3	0	39.6	42.1	0	121	127	0	29	29
2025	11	30	9	1	10	24.4	-1.6	0.94	0.3	0.2	0	39.6	41.7	0	121	126	0	29	29
2025	11	30	9	11	10	24.6	-1.3	0.94	0.6	0.5	0	39.1	41.3	0	120	125	0	29	29
2025	11	30	9	21	10	23.7	-2	0.94	0.5	0.4	0	39.1	40.9	0	120	125	0	29	30
2025	11	30	9	31	10	25.5	-1.8	0.94	0.5	0.4	0	39.6	41.3	0	121	126	0	29	30
2025	11	30	9	41	10	25.8	-1.8	0.94	0.4	0.3	0	39.1	41.3	0	120	125	0	29	29
2025	11	30	9	51	10	25.9	-1.9	0.94	0.5	0.4	0	39.1	41.3	0	120	125	0	29	29
2025	11	30	10	1	10	25.4	-2.6	0.94	0.5	0.4	0	39.6	41.3	0	120	125	0	28	29
2025	11	30	10	11	10	24.8	-2.7	0.94	0.5	0.4	0	39.1	41.7	0	120	126	0	29	29
2025	11	30	10	21	10	25.8	-3.6	0.94	0.4	0.3	0	38.7	40.9	0	119	124	0	29	29
2025	11	30	10	31	10	24.3	-1.7	0.94	0.5	0.4	0	39.1	41.3	0	120	125	0	29	29
2025	11	30	10	41	10	24.7	-2.4	0.94	0.4	0.3	0	38.7	40.9	0	119	124	0	29	29
2025	11	30	10	51	10	25.3	-2.8	0.94	0.3	0.2	0	39.1	41.3	0	120	126	0	29	30
2025	11	30	11	1	10	25.9	-3.1	0.94	0.4	0.3	0	39.1	41.3	0	120	125	0	29	29
2025	11	30	11	11	10	24.9	-3.1	0.94	0.5	0.4	0	40.9	43	0	124	129	0	29	29
2025	11	30	11	21	10	24.8	-2.7	0.94	0.4	0.3	0	40	42.6	0	122	128	0	29	29
2025	11	30	11	31	10	24.4	-2	0.94	0.4	0.3	0	40.9	42.6	0	123	128	0	28	29
2025	11	30	11	41	10	24.3	-2.2	0.941	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	30	11	51	10	24.7	-1.6	0.941	0.4	0.3	0	40.4	42.6	0	123	128	0	29	29
2025	11	30	12	1	10	26.4	-1.4	0.941	0.5	0.4	0	42.1	44.3	0	127	132	0	29	29
2025	11	30	12	11	10	26.1	-2.8	0.941	0.4	0.3	0	43	45.2	0	129	134	0	29	29
2025	11	30	12	21	10	24.4	-0.7	0.941	0.4	0.3	0	40.9	42.6	0	124	129	0	29	30
2025	11	30	12	31	10	25.4	-0.7	0.941	0.5	0.4	0	41.7	43.9	0	126	131	0	29	29
2025	11	30	12	41	10	24.8	-2.1	0.941	0.4	0.3	0	43.9	45.6	0	130	135	0	28	29
2025	11	30	12	51	10	25.6	-2	0.941	0.6	0.5	0	40	41.7	0	122	127	0	29	30
2025	11	30	13	1	10	24.7	-3.3	0.941	0.5	0.4	0	39.1	41.7	0	121	126	0	30	29
2025	11	30	13	11	10	26.4	-2.8	0.941	0.4	0.3	0	38.7	40.9	0	119	124	0	29	29
2025	11	30	13	21	10	24.6	-2.1	0.941	0.5	0.4	0	39.6	41.7	0	121	126	0	29	29
2025	11	30	13	31	10	24.8	-2.3	0.941	0.4	0.3	0	39.1	41.3	0	120	125	0	29	29
2025	11	30	13	41	10	24.6	-2.9	0.941	0.5	0.4	0	39.1	41.3	0	120	125	0	29	29
2025	11	30	13	51	10	25.4	-2.6	0.941	0.4	0.3	0	39.6	40.9	0	120	125	0	28	30
2025	11	30	14	1	10	24.4	-2.5	0.942	0.5	0.4	0	39.6	41.7	0	121	126	0	29	29
2025	11	30	14	11	10	25	-2	0.942	0.4	0.3	0	39.1	41.3	0	120	125	0	29	29
2025	11	30	14	21	10	25.9	-2.9	0.942	0.4	0.3	0	38.7	40.9	0	119	124	0	29	29
2025	11	30	14	31	10	24.6	-2.9	0.942	0.5	0.4	0	39.1	41.3	0	120	125	0	29	29
2025	11	30	14	41	10	25.8	-2.6	0.942	0.5	0.4	0	38.7	40.9	0	119	124	0	29	29
2025	11	30	14	51	10	25.9	-3.1	0.942	0.5	0.4	0	39.1	40.9	0	120	125	0	29	30
2025	11	30	15	1	10	26.4	-2	0.942	0.5	0.4	0	39.1	41.3	0	120	125	0	29	29
2025	11	30	15	11	10	25.4	-3	0.942	0.5	0.4	0	39.1	41.3	0	120	125	0	29	29
2025	11	30	15	21	10	25.5	-2	0.942	0.5	0.4	0	39.1	41.3	0	120	125	0	29	29
2025	11	30	15	31	10	24.6	-2.4	0.942	0.5	0.4	0	40.9	42.6	0	123	128	0	28	29
2025	11	30	15	41	10	25.7	-2.2	0.942	0.5	0.5	0	40	42.1	0	122	127	0	29	29
2025	11	30	15	51	10	25.8	-2.6	0.942	0.4	0.3	0	40.4	42.6	0	123	128	0	29	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2025	11	30	16	1	10	25	-2.8	0.942	0.5	0.4	0	40.4	42.6	0	122	128	0	28	29
2025	11	30	16	11	10	25.7	-2.5	0.942	0.4	0.3	0	39.6	41.3	0	121	126	0	29	30
2025	11	30	16	21	10	25.2	-2.2	0.942	0.5	0.4	0	39.1	41.7	0	120	126	0	29	29
2025	11	30	16	31	10	25.5	-2	0.942	0.3	0.2	0	39.6	41.3	0	121	126	0	29	30
2025	11	30	16	41	10	25	-2.5	0.942	0.3	0.2	0	39.1	40.9	0	120	125	0	29	30
2025	11	30	16	51	10	25.2	-2	0.942	0.4	0.3	0	40	41.7	0	121	126	0	28	29
2025	11	30	17	1	10	24.6	-2	0.942	0.5	0.4	0	39.1	41.3	0	120	125	0	29	29
2025	11	30	17	11	10	24.7	-2.5	0.942	0.5	0.4	0	39.1	41.7	0	120	126	0	29	29
2025	11	30	17	21	10	25.1	-2.6	0.942	0.4	0.3	0	39.1	40.9	0	120	125	0	29	30
2025	11	30	17	31	10	25.8	-2.1	0.942	0.5	0.5	0	39.1	41.3	0	120	125	0	29	29
2025	11	30	17	41	10	25.3	-2.9	0.942	0.5	0.4	0	38.7	40.9	0	119	124	0	29	29
2025	11	30	17	51	10	25.4	-2.7	0.943	0.5	0.4	0	38.7	41.3	0	119	125	0	29	29
2025	11	30	18	1	10	25.2	-1.9	0.942	0.5	0.4	0	38.7	41.3	0	119	125	0	29	29
2025	11	30	18	11	10	25.8	-2	0.942	0.3	0.2	0	39.1	40.9	0	120	125	0	29	30
2025	11	30	18	21	10	25.2	-3.3	0.943	0.5	0.4	0	39.6	41.3	0	120	125	0	28	29
2025	11	30	18	31	10	24.2	-2.4	0.942	0.5	0.5	0	39.6	41.7	0	120	126	0	28	29
2025	11	30	18	41	10	24.9	-2.4	0.943	0.4	0.3	0	39.1	41.7	0	120	126	0	29	29
2025	11	30	18	51	10	25.5	-1.8	0.942	0.4	0.3	0	39.1	41.7	0	120	126	0	29	29
2025	11	30	19	1	10	24.5	-2.3	0.943	0.5	0.4	0	39.6	41.7	0	121	126	0	29	29
2025	11	30	19	11	10	24.9	-2.7	0.943	0.5	0.4	0	39.6	42.1	0	121	127	0	29	29
2025	11	30	19	21	10	25	-3.2	0.943	0.4	0.3	0	39.6	41.7	0	121	126	0	29	29
2025	11	30	19	31	10	25.4	-3.2	0.942	0.5	0.4	0	39.6	42.1	0	121	127	0	29	29
2025	11	30	19	41	10	25.4	-1.3	0.942	0.5	0.4	0	39.6	41.7	0	121	126	0	29	29
2025	11	30	19	51	10	26	-2.7	0.943	0.5	0.4	0	39.6	42.1	0	121	126	0	29	28
2025	11	30	20	1	10	25.3	-2.4	0.942	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	30	20	11	10	25	-3.6	0.942	0.5	0.4	0	40	41.7	0	122	127	0	29	30
2025	11	30	20	21	10	25.2	-2.2	0.943	0.5	0.4	0	40	42.1	0	122	127	0	29	29
2025	11	30	20	31	10	25	-3	0.942	0.5	0.4	0	39.6	41.7	0	121	126	0	29	29
2025	11	30	20	41	10	26.2	-2	0.942	0.4	0.3	0	39.6	42.1	0	121	127	0	29	29
2025	11	30	20	51	10	25.6	-2.6	0.943	0.5	0.4	0	39.6	41.3	0	121	126	0	29	30
2025	11	30	21	1	10	25.7	-2.2	0.942	0.5	0.4	0	39.6	41.3	0	120	125	0	28	29
2025	11	30	21	11	10	26	-2.8	0.942	0.5	0.4	0	39.6	41.7	0	121	126	0	29	29
2025	11	30	21	21	10	24.8	-3.1	0.942	0.4	0.3	0	40	42.1	0	121	127	0	28	29
2025	11	30	21	31	10	24.9	-2.5	0.942	0.4	0.3	0	39.1	41.3	0	120	126	0	29	30
2025	11	30	21	41	10	23.6	-2.5	0.942	0.5	0.4	0	39.6	41.7	0	121	126	0	29	29
2025	11	30	21	51	10	24.9	-1.6	0.942	0.5	0.4	0	39.6	41.7	0	121	127	0	29	30
2025	11	30	22	1	10	23.9	-1.7	0.943	0.4	0.3	0	40	43	0	122	128	0	29	28
2025	11	30	22	11	10	24.3	-1.8	0.942	0.6	0.5	0	40.4	43	0	123	129	0	29	29
2025	11	30	22	21	10	25.2	-2.4	0.942	0.3	0.2	0	39.6	42.1	0	121	127	0	29	29
2025	11	30	22	31	10	25.4	-1.5	0.942	0.5	0.4	0	39.6	41.7	0	120	126	0	28	29
2025	11	30	22	41	10	25.1	-3.4	0.943	0.5	0.4	0	40	42.6	0	122	128	0	29	29
2025	11	30	22	51	10	26.1	-2.2	0.943	0.5	0.4	0	39.1	41.3	0	120	125	0	29	29
2025	11	30	23	1	10	25.2	-2	0.942	0.5	0.5	0	39.6	41.7	0	121	126	0	29	29
2025	11	30	23	11	10	24.1	-1.3	0.943	0.6	0.5	0	39.6	42.1	0	121	127	0	29	29
2025	11	30	23	21	10	24.8	-2.5	0.943	0.4	0.3	0	39.1	41.7	0	120	126	0	29	29
2025	11	30	23	31	10	24.3	-2.3	0.943	0.5	0.5	0	39.6	41.7	0	121	126	0	29	29
2025	11	30	23	41	10	25.1	-2.3	0.943	0.5	0.5	0	40	42.1	0	121	127	0	28	29
2025	11	30	23	51	10	24.2	-2.5	0.943	0.5	0.4	0	39.1	41.7	0	120	126	0	29	29

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	1	0	0	0	27	0	0	0	0	0	0	0	11.66	0	0
2025	11	1	0	10	0	26	0	0	0	0	0	0	0	11.63	0	0
2025	11	1	0	20	0	26	0	0	0	0	0	0	0	11.6	0	0
2025	11	1	0	30	0	27	0	0	0	0	0	0	0	11.55	0	0
2025	11	1	0	40	0	26	0	0	0	0	0	0	0	11.51	0	0
2025	11	1	0	50	0	27	0	0	0	0	0	0	0	11.48	0	0
2025	11	1	1	0	0	27	0	0	0	0	0	0	0	11.44	0	0
2025	11	1	1	10	0	26	0	0	0	0	0	0	0	11.41	0	0
2025	11	1	1	20	0	27	0	0	0	0	0	0	0	11.38	0	0
2025	11	1	1	30	0	27	0	0	0	0	0	0	0	11.35	0	0
2025	11	1	1	40	0	27	0	0	0	0	0	0	0	11.31	0	0
2025	11	1	1	50	0	28	0	0	0	0	0	0	0	11.28	0	0
2025	11	1	2	0	0	27	0	0	0	0	0	0	0	11.26	0	0
2025	11	1	2	10	0	27	0	0	0	0	0	0	0	11.23	0	0
2025	11	1	2	20	0	27	0	0	0	0	0	0	0	11.2	0	0
2025	11	1	2	30	0	27	0	0	0	0	0	0	0	11.17	0	0
2025	11	1	2	40	0	27	0	0	0	0	0	0	0	11.14	0	0
2025	11	1	2	50	0	27	0	0	0	0	0	0	0	11.11	0	0
2025	11	1	3	0	0	26	0	0	0	0	0	0	0	11.09	0	0
2025	11	1	3	10	0	27	0	0	0	0	0	0	0	11.08	0	0
2025	11	1	3	20	0	27	0	0	0	0	0	0	0	11.05	0	0
2025	11	1	3	30	0	27	0	0	0	0	0	0	0	11.03	0	0
2025	11	1	3	40	0	27	0	0	0	0	0	0	0	11.01	0	0
2025	11	1	3	50	0	27	0	0	0	0	0	0	0	10.99	0	0
2025	11	1	4	0	0	27	0	0	0	0	0	0	0	10.97	0	0
2025	11	1	4	10	0	27	0	0	0	0	0	0	0	10.95	0	0
2025	11	1	4	20	0	27	0	0	0	0	0	0	0	10.93	0	0
2025	11	1	4	30	0	27	0	0	0	0	0	0	0	10.92	0	0
2025	11	1	4	40	0	27	0	0	0	0	0	0	0	10.9	0	0
2025	11	1	4	50	0	28	0	0	0	0	0	0	0	10.88	0	0
2025	11	1	5	0	0	27	0	0	0	0	0	0	0	10.86	0	0
2025	11	1	5	10	0	27	0	0	0	0	0	0	0	10.85	0	0
2025	11	1	5	20	0	27	0	0	0	0	0	0	0	10.83	0	0
2025	11	1	5	30	0	27	0	0	0	0	0	0	0	10.81	0	0
2025	11	1	5	40	0	27	0	0	0	0	0	0	0	10.79	0	0
2025	11	1	5	50	0	26	0	0	0	0	0	0	0	10.78	0	0
2025	11	1	6	0	0	27	0	0	0	0	0	0	0	10.76	0	0
2025	11	1	6	10	0	27	0	0	0	0	0	0	0	10.74	0	0
2025	11	1	6	20	0	27	0	0	0	0	0	0	0	10.72	0	0
2025	11	1	6	30	0	28	0	0	0	0	0	0	0	10.71	0	0
2025	11	1	6	40	0	27	0	0	0	0	0	0	0	10.7	0	0
2025	11	1	6	50	0	27	0	0	0	0	0	0	0	10.68	0	0
2025	11	1	7	0	0	27	0	0	0	0	0	0	0	10.66	0	0
2025	11	1	7	10	0	27	0	0	0	0	0	0	0	10.65	0	0
2025	11	1	7	20	0	27	0	0	0	0	0	0	0	10.64	0	0
2025	11	1	7	30	0	27	0	0	0	0	0	0	0	10.62	0	0
2025	11	1	7	40	0	27	0	0	0	0	0	0	0	10.61	0	0
2025	11	1	7	50	0	28	0	0	0	0	0	0	0	10.6	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	1	8	0	0	27	0	0	0	0	0	0	0	10.58	0	0
2025	11	1	8	10	0	27	0	0	0	0	0	0	0	10.57	0	0
2025	11	1	8	20	0	27	0	0	0	0	0	0	0	10.56	0	0
2025	11	1	8	30	0	27	0	0	0	0	0	0	0	10.55	0	0
2025	11	1	8	40	0	26	0	0	0	0	0	0	0	10.56	0	0
2025	11	1	8	50	0	27	0	0	0	0	0	0	0	10.57	0	0
2025	11	1	9	0	0	27	0	0	0	0	0	0	0	10.58	0	0
2025	11	1	9	10	0	27	0	0	0	0	0	0	0	10.6	0	0
2025	11	1	9	20	0	27	0	0	0	0	0	0	0	10.62	0	0
2025	11	1	9	30	0	27	0	0	0	0	0	0	0	10.64	0	0
2025	11	1	9	40	0	27	0	0	0	0	0	0	0	10.67	0	0
2025	11	1	9	50	0	28	0	0	0	0	0	0	0	10.7	0	0
2025	11	1	10	0	0	27	0	0	0	0	0	0	0	10.74	0	0
2025	11	1	10	10	0	27	0	0	0	0	0	0	0	10.78	0	0
2025	11	1	10	20	0	27	0	0	0	0	0	0	0	10.82	0	0
2025	11	1	10	30	0	27	0	0	0	0	0	0	0	10.87	0	0
2025	11	1	10	40	0	27	0	0	0	0	0	0	0	10.93	0	0
2025	11	1	10	50	0	27	0	0	0	0	0	0	0	10.99	0	0
2025	11	1	11	0	0	27	0	0	0	0	0	0	0	11.04	0	0
2025	11	1	11	10	0	27	0	0	0	0	0	0	0	11.11	0	0
2025	11	1	11	20	0	27	0	0	0	0	0	0	0	11.17	0	0
2025	11	1	11	30	0	26	0	0	0	0	0	0	0	11.23	0	0
2025	11	1	11	40	0	28	0	0	0	0	0	0	0	11.29	0	0
2025	11	1	11	50	0	27	0	0	0	0	0	0	0	11.36	0	0
2025	11	1	12	0	0	28	0	0	0	0	0	0	0	11.43	0	0
2025	11	1	12	10	0	28	0	0	0	0	0	0	0	11.48	0	0
2025	11	1	12	20	0	27	0	0	0	0	0	0	0	11.55	0	0
2025	11	1	12	30	0	27	0	0	0	0	0	0	0	11.62	0	0
2025	11	1	12	40	0	28	0	0	0	0	0	0	0	11.68	0	0
2025	11	1	12	50	0	27	0	0	0	0	0	0	0	11.74	0	0
2025	11	1	13	0	0	27	0	0	0	0	0	0	0	11.8	0	0
2025	11	1	13	10	0	27	0	0	0	0	0	0	0	11.86	0	0
2025	11	1	13	20	0	27	0	0	0	0	0	0	0	11.92	0	0
2025	11	1	13	30	0	27	0	0	0	0	0	0	0	11.98	0	0
2025	11	1	13	40	0	27	0	0	0	0	0	0	0	12.04	0	0
2025	11	1	13	50	0	27	0	0	0	0	0	0	0	12.09	0	0
2025	11	1	14	0	0	27	0	0	0	0	0	0	0	12.15	0	0
2025	11	1	14	10	0	27	0	0	0	0	0	0	0	12.2	0	0
2025	11	1	14	20	0	27	0	0	0	0	0	0	0	12.25	0	0
2025	11	1	14	30	0	27	0	0	0	0	0	0	0	12.3	0	0
2025	11	1	14	40	0	26	0	0	0	0	0	0	0	12.35	0	0
2025	11	1	14	50	0	27	0	0	0	0	0	0	0	12.39	0	0
2025	11	1	15	0	0	27	0	0	0	0	0	0	0	12.43	0	0
2025	11	1	15	10	0	27	0	0	0	0	0	0	0	12.47	0	0
2025	11	1	15	20	0	27	0	0	0	0	0	0	0	12.51	0	0
2025	11	1	15	30	0	27	0	0	0	0	0	0	0	12.54	0	0
2025	11	1	15	40	0	28	0	0	0	0	0	0	0	12.57	0	0
2025	11	1	15	50	0	26	0	0	0	0	0	0	0	12.6	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	2	0	0	0	27	0	0	0	0	0	0	0	11.6	0	0
2025	11	2	0	10	0	27	0	0	0	0	0	0	0	11.57	0	0
2025	11	2	0	20	0	27	0	0	0	0	0	0	0	11.53	0	0
2025	11	2	0	30	0	27	0	0	0	0	0	0	0	11.5	0	0
2025	11	2	0	40	0	27	0	0	0	0	0	0	0	11.46	0	0
2025	11	2	0	50	0	27	0	0	0	0	0	0	0	11.42	0	0
2025	11	2	1	0	0	27	0	0	0	0	0	0	0	11.39	0	0
2025	11	2	1	10	0	27	0	0	0	0	0	0	0	11.35	0	0
2025	11	2	1	20	0	27	0	0	0	0	0	0	0	11.32	0	0
2025	11	2	1	30	0	27	0	0	0	0	0	0	0	11.28	0	0
2025	11	2	1	40	0	27	0	0	0	0	0	0	0	11.26	0	0
2025	11	2	1	50	0	27	0	0	0	0	0	0	0	11.22	0	0
2025	11	2	2	0	0	27	0	0	0	0	0	0	0	11.19	0	0
2025	11	2	2	10	0	27	0	0	0	0	0	0	0	11.16	0	0
2025	11	2	2	20	0	27	0	0	0	0	0	0	0	11.12	0	0
2025	11	2	2	30	0	28	0	0	0	0	0	0	0	11.1	0	0
2025	11	2	2	40	0	28	0	0	0	0	0	0	0	11.07	0	0
2025	11	2	2	50	0	28	0	0	0	0	0	0	0	11.04	0	0
2025	11	2	3	0	0	27	0	0	0	0	0	0	0	11.02	0	0
2025	11	2	3	10	0	27	0	0	0	0	0	0	0	10.99	0	0
2025	11	2	3	20	0	28	0	0	0	0	0	0	0	10.97	0	0
2025	11	2	3	30	0	28	0	0	0	0	0	0	0	10.95	0	0
2025	11	2	3	40	0	27	0	0	0	0	0	0	0	10.93	0	0
2025	11	2	3	50	0	27	0	0	0	0	0	0	0	10.9	0	0
2025	11	2	4	0	0	26	0	0	0	0	0	0	0	10.88	0	0
2025	11	2	4	10	0	27	0	0	0	0	0	0	0	10.86	0	0
2025	11	2	4	20	0	27	0	0	0	0	0	0	0	10.84	0	0
2025	11	2	4	30	0	27	0	0	0	0	0	0	0	10.82	0	0
2025	11	2	4	40	0	26	0	0	0	0	0	0	0	10.8	0	0
2025	11	2	4	50	0	27	0	0	0	0	0	0	0	10.78	0	0
2025	11	2	5	0	0	27	0	0	0	0	0	0	0	10.77	0	0
2025	11	2	5	10	0	27	0	0	0	0	0	0	0	10.75	0	0
2025	11	2	5	20	0	27	0	0	0	0	0	0	0	10.73	0	0
2025	11	2	5	30	0	28	0	0	0	0	0	0	0	10.71	0	0
2025	11	2	5	40	0	27	0	0	0	0	0	0	0	10.69	0	0
2025	11	2	5	50	0	27	0	0	0	0	0	0	0	10.67	0	0
2025	11	2	6	0	0	28	0	0	0	0	0	0	0	10.65	0	0
2025	11	2	6	10	0	27	0	0	0	0	0	0	0	10.64	0	0
2025	11	2	6	20	0	27	0	0	0	0	0	0	0	10.62	0	0
2025	11	2	6	30	0	27	0	0	0	0	0	0	0	10.61	0	0
2025	11	2	6	40	0	27	0	0	0	0	0	0	0	10.59	0	0
2025	11	2	6	50	0	27	0	0	0	0	0	0	0	10.57	0	0
2025	11	2	7	0	0	27	0	0	0	0	0	0	0	10.56	0	0
2025	11	2	7	10	0	27	0	0	0	0	0	0	0	10.54	0	0
2025	11	2	7	20	0	27	0	0	0	0	0	0	0	10.53	0	0
2025	11	2	7	30	0	27	0	0	0	0	0	0	0	10.51	0	0
2025	11	2	7	40	0	27	0	0	0	0	0	0	0	10.5	0	0
2025	11	2	7	50	0	27	0	0	0	0	0	0	0	10.49	0	0

Mazourka (0354)

	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	2	8	0	0	27	0	0	0	0	0	0	0	10.47	0	0
2025	11	2	8	10	0	27	0	0	0	0	0	0	0	10.46	0	0
2025	11	2	8	20	0	26	0	0	0	0	0	0	0	10.45	0	0
2025	11	2	8	30	0	28	0	0	0	0	0	0	0	10.44	0	0
2025	11	2	8	40	0	28	0	0	0	0	0	0	0	10.44	0	0
2025	11	2	8	50	0	27	0	0	0	0	0	0	0	10.45	0	0
2025	11	2	9	0	0	28	0	0	0	0	0	0	0	10.45	0	0
2025	11	2	9	10	0	27	0	0	0	0	0	0	0	10.47	0	0
2025	11	2	9	20	0	27	0	0	0	0	0	0	0	10.48	0	0
2025	11	2	9	30	0	28	0	0	0	0	0	0	0	10.5	0	0
2025	11	2	9	40	0	28	0	0	0	0	0	0	0	10.52	0	0
2025	11	2	9	50	0	27	0	0	0	0	0	0	0	10.55	0	0
2025	11	2	10	0	0	27	0	0	0	0	0	0	0	10.58	0	0
2025	11	2	10	10	0	27	0	0	0	0	0	0	0	10.61	0	0
2025	11	2	10	20	0	27	0	0	0	0	0	0	0	10.65	0	0
2025	11	2	10	30	0	27	0	0	0	0	0	0	0	10.7	0	0
2025	11	2	10	40	0	27	0	0	0	0	0	0	0	10.74	0	0
2025	11	2	10	50	0	27	0	0	0	0	0	0	0	10.8	0	0
2025	11	2	11	0	0	27	0	0	0	0	0	0	0	10.84	0	0
2025	11	2	11	10	0	28	0	0	0	0	0	0	0	10.9	0	0
2025	11	2	11	20	0	28	0	0	0	0	0	0	0	10.96	0	0
2025	11	2	11	30	0	27	0	0	0	0	0	0	0	11.02	0	0
2025	11	2	11	40	0	27	0	0	0	0	0	0	0	11.08	0	0
2025	11	2	11	50	0	27	0	0	0	0	0	0	0	11.13	0	0
2025	11	2	12	0	0	27	0	0	0	0	0	0	0	11.19	0	0
2025	11	2	12	10	0	27	0	0	0	0	0	0	0	11.26	0	0
2025	11	2	12	20	0	27	0	0	0	0	0	0	0	11.32	0	0
2025	11	2	12	30	0	27	0	0	0	0	0	0	0	11.36	0	0
2025	11	2	12	40	0	27	0	0	0	0	0	0	0	11.41	0	0
2025	11	2	12	50	0	27	0	0	0	0	0	0	0	11.46	0	0
2025	11	2	13	0	0	27	0	0	0	0	0	0	0	11.52	0	0
2025	11	2	13	10	0	27	0	0	0	0	0	0	0	11.58	0	0
2025	11	2	13	20	0	27	0	0	0	0	0	0	0	11.63	0	0
2025	11	2	13	30	0	27	0	0	0	0	0	0	0	11.68	0	0
2025	11	2	13	40	0	27	0	0	0	0	0	0	0	11.75	0	0
2025	11	2	13	50	0	28	0	0	0	0	0	0	0	11.79	0	0
2025	11	2	14	0	0	27	0	0	0	0	0	0	0	11.82	0	0
2025	11	2	14	10	0	27	0	0	0	0	0	0	0	11.87	0	0
2025	11	2	14	20	0	27	0	0	0	0	0	0	0	11.93	0	0
2025	11	2	14	30	0	27	0	0	0	0	0	0	0	11.99	0	0
2025	11	2	14	40	0	28	0	0	0	0	0	0	0	12.04	0	0
2025	11	2	14	50	0	27	0	0	0	0	0	0	0	12.08	0	0
2025	11	2	15	0	0	27	0	0	0	0	0	0	0	12.13	0	0
2025	11	2	15	10	0	27	0	0	0	0	0	0	0	12.16	0	0
2025	11	2	15	20	0	27	0	0	0	0	0	0	0	12.19	0	0
2025	11	2	15	30	0	28	0	0	0	0	0	0	0	12.23	0	0
2025	11	2	15	40	0	27	0	0	0	0	0	0	0	12.26	0	0
2025	11	2	15	50	0	28	0	0	0	0	0	0	0	12.29	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	3	0	0	0	26	0	0	0	0	0	0	0	11.29	0	0
2025	11	3	0	10	0	27	0	0	0	0	0	0	0	11.26	0	0
2025	11	3	0	20	0	27	0	0	0	0	0	0	0	11.22	0	0
2025	11	3	0	30	0	28	0	0	0	0	0	0	0	11.19	0	0
2025	11	3	0	40	0	27	0	0	0	0	0	0	0	11.15	0	0
2025	11	3	0	50	0	27	0	0	0	0	0	0	0	11.12	0	0
2025	11	3	1	0	0	27	0	0	0	0	0	0	0	11.09	0	0
2025	11	3	1	10	0	27	0	0	0	0	0	0	0	11.05	0	0
2025	11	3	1	20	0	27	0	0	0	0	0	0	0	11.01	0	0
2025	11	3	1	30	0	28	0	0	0	0	0	0	0	10.98	0	0
2025	11	3	1	40	0	27	0	0	0	0	0	0	0	10.95	0	0
2025	11	3	1	50	0	27	0	0	0	0	0	0	0	10.92	0	0
2025	11	3	2	0	0	27	0	0	0	0	0	0	0	10.88	0	0
2025	11	3	2	10	0	28	0	0	0	0	0	0	0	10.85	0	0
2025	11	3	2	20	0	27	0	0	0	0	0	0	0	10.82	0	0
2025	11	3	2	30	0	28	0	0	0	0	0	0	0	10.79	0	0
2025	11	3	2	40	0	27	0	0	0	0	0	0	0	10.77	0	0
2025	11	3	2	50	0	28	0	0	0	0	0	0	0	10.74	0	0
2025	11	3	3	0	0	27	0	0	0	0	0	0	0	10.72	0	0
2025	11	3	3	10	0	27	0	0	0	0	0	0	0	10.69	0	0
2025	11	3	3	20	0	28	0	0	0	0	0	0	0	10.67	0	0
2025	11	3	3	30	0	27	0	0	0	0	0	0	0	10.65	0	0
2025	11	3	3	40	0	27	0	0	0	0	0	0	0	10.63	0	0
2025	11	3	3	50	0	27	0	0	0	0	0	0	0	10.61	0	0
2025	11	3	4	0	0	28	0	0	0	0	0	0	0	10.59	0	0
2025	11	3	4	10	0	27	0	0	0	0	0	0	0	10.57	0	0
2025	11	3	4	20	0	27	0	0	0	0	0	0	0	10.56	0	0
2025	11	3	4	30	0	27	0	0	0	0	0	0	0	10.54	0	0
2025	11	3	4	40	0	27	0	0	0	0	0	0	0	10.52	0	0
2025	11	3	4	50	0	28	0	0	0	0	0	0	0	10.51	0	0
2025	11	3	5	0	0	27	0	0	0	0	0	0	0	10.49	0	0
2025	11	3	5	10	0	27	0	0	0	0	0	0	0	10.48	0	0
2025	11	3	5	20	0	27	0	0	0	0	0	0	0	10.46	0	0
2025	11	3	5	30	0	26	0	0	0	0	0	0	0	10.44	0	0
2025	11	3	5	40	0	28	0	0	0	0	0	0	0	10.42	0	0
2025	11	3	5	50	0	27	0	0	0	0	0	0	0	10.4	0	0
2025	11	3	6	0	0	28	0	0	0	0	0	0	0	10.38	0	0
2025	11	3	6	10	0	28	0	0	0	0	0	0	0	10.36	0	0
2025	11	3	6	20	0	27	0	0	0	0	0	0	0	10.34	0	0
2025	11	3	6	30	0	27	0	0	0	0	0	0	0	10.32	0	0
2025	11	3	6	40	0	27	0	0	0	0	0	0	0	10.3	0	0
2025	11	3	6	50	0	27	0	0	0	0	0	0	0	10.28	0	0
2025	11	3	7	0	0	28	0	0	0	0	0	0	0	10.27	0	0
2025	11	3	7	10	0	27	0	0	0	0	0	0	0	10.25	0	0
2025	11	3	7	20	0	27	0	0	0	0	0	0	0	10.23	0	0
2025	11	3	7	30	0	27	0	0	0	0	0	0	0	10.21	0	0
2025	11	3	7	40	0	27	0	0	0	0	0	0	0	10.2	0	0
2025	11	3	7	50	0	27	0	0	0	0	0	0	0	10.18	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	3	8	0	0	27	0	0	0	0	0	0	0	10.17	0	0
2025	11	3	8	10	0	28	0	0	0	0	0	0	0	10.15	0	0
2025	11	3	8	20	0	27	0	0	0	0	0	0	0	10.13	0	0
2025	11	3	8	30	0	28	0	0	0	0	0	0	0	10.13	0	0
2025	11	3	8	40	0	27	0	0	0	0	0	0	0	10.13	0	0
2025	11	3	8	50	0	27	0	0	0	0	0	0	0	10.13	0	0
2025	11	3	9	0	0	28	0	0	0	0	0	0	0	10.14	0	0
2025	11	3	9	10	0	27	0	0	0	0	0	0	0	10.14	0	0
2025	11	3	9	20	0	27	0	0	0	0	0	0	0	10.16	0	0
2025	11	3	9	30	0	27	0	0	0	0	0	0	0	10.18	0	0
2025	11	3	9	40	0	27	0	0	0	0	0	0	0	10.2	0	0
2025	11	3	9	50	0	28	0	0	0	0	0	0	0	10.23	0	0
2025	11	3	10	0	0	28	0	0	0	0	0	0	0	10.25	0	0
2025	11	3	10	10	0	27	0	0	0	0	0	0	0	10.29	0	0
2025	11	3	10	20	0	27	0	0	0	0	0	0	0	10.33	0	0
2025	11	3	10	30	0	27	0	0	0	0	0	0	0	10.37	0	0
2025	11	3	10	40	0	28	0	0	0	0	0	0	0	10.42	0	0
2025	11	3	10	50	0	27	0	0	0	0	0	0	0	10.47	0	0
2025	11	3	11	0	0	27	0	0	0	0	0	0	0	10.52	0	0
2025	11	3	11	10	0	28	0	0	0	0	0	0	0	10.58	0	0
2025	11	3	11	20	0	27	0	0	0	0	0	0	0	10.63	0	0
2025	11	3	11	30	0	26	0	0	0	0	0	0	0	10.69	0	0
2025	11	3	11	40	0	27	0	0	0	0	0	0	0	10.75	0	0
2025	11	3	11	50	0	27	0	0	0	0	0	0	0	10.81	0	0
2025	11	3	12	0	0	27	0	0	0	0	0	0	0	10.88	0	0
2025	11	3	12	10	0	27	0	0	0	0	0	0	0	10.94	0	0
2025	11	3	12	20	0	27	0	0	0	0	0	0	0	11.01	0	0
2025	11	3	12	30	0	27	0	0	0	0	0	0	0	11.07	0	0
2025	11	3	12	40	0	27	0	0	0	0	0	0	0	11.13	0	0
2025	11	3	12	50	0	27	0	0	0	0	0	0	0	11.2	0	0
2025	11	3	13	0	0	27	0	0	0	0	0	0	0	11.27	0	0
2025	11	3	13	10	0	27	0	0	0	0	0	0	0	11.32	0	0
2025	11	3	13	20	0	27	0	0	0	0	0	0	0	11.38	0	0
2025	11	3	13	30	0	26	0	0	0	0	0	0	0	11.44	0	0
2025	11	3	13	40	0	27	0	0	0	0	0	0	0	11.5	0	0
2025	11	3	13	50	0	27	0	0	0	0	0	0	0	11.55	0	0
2025	11	3	14	0	0	27	0	0	0	0	0	0	0	11.61	0	0
2025	11	3	14	10	0	27	0	0	0	0	0	0	0	11.66	0	0
2025	11	3	14	20	0	27	0	0	0	0	0	0	0	11.72	0	0
2025	11	3	14	30	0	27	0	0	0	0	0	0	0	11.76	0	0
2025	11	3	14	40	0	27	0	0	0	0	0	0	0	11.81	0	0
2025	11	3	14	50	0	26	0	0	0	0	0	0	0	11.85	0	0
2025	11	3	15	0	0	27	0	0	0	0	0	0	0	11.89	0	0
2025	11	3	15	10	0	27	0	0	0	0	0	0	0	11.93	0	0
2025	11	3	15	20	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	3	15	30	0	27	0	0	0	0	0	0	0	12.01	0	0
2025	11	3	15	40	0	27	0	0	0	0	0	0	0	12.04	0	0
2025	11	3	15	50	0	27	0	0	0	0	0	0	0	12.06	0	0

Mazourka (0354)

	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	3	16	0	0	27	0	0	0	0	0	0	0	12.09	0	0
2025	11	3	16	10	0	27	0	0	0	0	0	0	0	12.11	0	0
2025	11	3	16	20	0	27	0	0	0	0	0	0	0	12.13	0	0
2025	11	3	16	30	0	27	0	0	0	0	0	0	0	12.15	0	0
2025	11	3	16	40	0	27	0	0	0	0	0	0	0	12.16	0	0
2025	11	3	16	50	0	28	0	0	0	0	0	0	0	12.18	0	0
2025	11	3	17	0	0	26	0	0	0	0	0	0	0	12.2	0	0
2025	11	3	17	10	0	27	0	0	0	0	0	0	0	12.21	0	0
2025	11	3	17	20	0	27	0	0	0	0	0	0	0	12.22	0	0
2025	11	3	17	30	0	27	0	0	0	0	0	0	0	12.23	0	0
2025	11	3	17	40	0	27	0	0	0	0	0	0	0	12.23	0	0
2025	11	3	17	50	0	27	0	0	0	0	0	0	0	12.24	0	0
2025	11	3	18	0	0	27	0	0	0	0	0	0	0	12.24	0	0
2025	11	3	18	10	0	26	0	0	0	0	0	0	0	12.23	0	0
2025	11	3	18	20	0	27	0	0	0	0	0	0	0	12.22	0	0
2025	11	3	18	30	0	27	0	0	0	0	0	0	0	12.22	0	0
2025	11	3	18	40	0	26	0	0	0	0	0	0	0	12.21	0	0
2025	11	3	18	50	0	27	0	0	0	0	0	0	0	12.19	0	0
2025	11	3	19	0	0	27	0	0	0	0	0	0	0	12.17	0	0
2025	11	3	19	10	0	27	0	0	0	0	0	0	0	12.15	0	0
2025	11	3	19	20	0	27	0	0	0	0	0	0	0	12.13	0	0
2025	11	3	19	30	0	27	0	0	0	0	0	0	0	12.1	0	0
2025	11	3	19	40	0	27	0	0	0	0	0	0	0	12.07	0	0
2025	11	3	19	50	0	27	0	0	0	0	0	0	0	12.04	0	0
2025	11	3	20	0	0	28	0	0	0	0	0	0	0	12.01	0	0
2025	11	3	20	10	0	27	0	0	0	0	0	0	0	11.98	0	0
2025	11	3	20	20	0	27	0	0	0	0	0	0	0	11.94	0	0
2025	11	3	20	30	0	27	0	0	0	0	0	0	0	11.91	0	0
2025	11	3	20	40	0	27	0	0	0	0	0	0	0	11.88	0	0
2025	11	3	20	50	0	27	0	0	0	0	0	0	0	11.85	0	0
2025	11	3	21	0	0	27	0	0	0	0	0	0	0	11.82	0	0
2025	11	3	21	10	0	27	0	0	0	0	0	0	0	11.79	0	0
2025	11	3	21	20	0	26	0	0	0	0	0	0	0	11.76	0	0
2025	11	3	21	30	0	26	0	0	0	0	0	0	0	11.73	0	0
2025	11	3	21	40	0	27	0	0	0	0	0	0	0	11.7	0	0
2025	11	3	21	50	0	27	0	0	0	0	0	0	0	11.67	0	0
2025	11	3	22	0	0	27	0	0	0	0	0	0	0	11.64	0	0
2025	11	3	22	10	0	27	0	0	0	0	0	0	0	11.61	0	0
2025	11	3	22	20	0	27	0	0	0	0	0	0	0	11.58	0	0
2025	11	3	22	30	0	28	0	0	0	0	0	0	0	11.55	0	0
2025	11	3	22	40	0	27	0	0	0	0	0	0	0	11.52	0	0
2025	11	3	22	50	0	26	0	0	0	0	0	0	0	11.49	0	0
2025	11	3	23	0	0	27	0	0	0	0	0	0	0	11.46	0	0
2025	11	3	23	10	0	27	0	0	0	0	0	0	0	11.43	0	0
2025	11	3	23	20	0	27	0	0	0	0	0	0	0	11.4	0	0
2025	11	3	23	30	0	27	0	0	0	0	0	0	0	11.37	0	0
2025	11	3	23	40	0	27	0	0	0	0	0	0	0	11.33	0	0
2025	11	3	23	50	0	27	0	0	0	0	0	0	0	11.3	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	4	0	0	0	27	0	0	0	0	0	0	0	11.27	0	0
2025	11	4	0	10	0	26	0	0	0	0	0	0	0	11.23	0	0
2025	11	4	0	20	0	28	0	0	0	0	0	0	0	11.19	0	0
2025	11	4	0	30	0	27	0	0	0	0	0	0	0	11.16	0	0
2025	11	4	0	40	0	27	0	0	0	0	0	0	0	11.12	0	0
2025	11	4	0	50	0	27	0	0	0	0	0	0	0	11.09	0	0
2025	11	4	1	0	0	28	0	0	0	0	0	0	0	11.05	0	0
2025	11	4	1	10	0	28	0	0	0	0	0	0	0	11.02	0	0
2025	11	4	1	20	0	28	0	0	0	0	0	0	0	10.99	0	0
2025	11	4	1	30	0	27	0	0	0	0	0	0	0	10.95	0	0
2025	11	4	1	40	0	27	0	0	0	0	0	0	0	10.92	0	0
2025	11	4	1	50	0	27	0	0	0	0	0	0	0	10.88	0	0
2025	11	4	2	0	0	27	0	0	0	0	0	0	0	10.85	0	0
2025	11	4	2	10	0	27	0	0	0	0	0	0	0	10.83	0	0
2025	11	4	2	20	0	26	0	0	0	0	0	0	0	10.79	0	0
2025	11	4	2	30	0	27	0	0	0	0	0	0	0	10.76	0	0
2025	11	4	2	40	0	27	0	0	0	0	0	0	0	10.73	0	0
2025	11	4	2	50	0	28	0	0	0	0	0	0	0	10.7	0	0
2025	11	4	3	0	0	27	0	0	0	0	0	0	0	10.68	0	0
2025	11	4	3	10	0	28	0	0	0	0	0	0	0	10.65	0	0
2025	11	4	3	20	0	27	0	0	0	0	0	0	0	10.63	0	0
2025	11	4	3	30	0	28	0	0	0	0	0	0	0	10.61	0	0
2025	11	4	3	40	0	27	0	0	0	0	0	0	0	10.59	0	0
2025	11	4	3	50	0	27	0	0	0	0	0	0	0	10.57	0	0
2025	11	4	4	0	0	28	0	0	0	0	0	0	0	10.55	0	0
2025	11	4	4	10	0	27	0	0	0	0	0	0	0	10.53	0	0
2025	11	4	4	20	0	27	0	0	0	0	0	0	0	10.51	0	0
2025	11	4	4	30	0	27	0	0	0	0	0	0	0	10.5	0	0
2025	11	4	4	40	0	28	0	0	0	0	0	0	0	10.48	0	0
2025	11	4	4	50	0	27	0	0	0	0	0	0	0	10.47	0	0
2025	11	4	5	0	0	27	0	0	0	0	0	0	0	10.46	0	0
2025	11	4	5	10	0	27	0	0	0	0	0	0	0	10.44	0	0
2025	11	4	5	20	0	28	0	0	0	0	0	0	0	10.42	0	0
2025	11	4	5	30	0	28	0	0	0	0	0	0	0	10.4	0	0
2025	11	4	5	40	0	26	0	0	0	0	0	0	0	10.38	0	0
2025	11	4	5	50	0	27	0	0	0	0	0	0	0	10.37	0	0
2025	11	4	6	0	0	28	0	0	0	0	0	0	0	10.34	0	0
2025	11	4	6	10	0	27	0	0	0	0	0	0	0	10.33	0	0
2025	11	4	6	20	0	27	0	0	0	0	0	0	0	10.31	0	0
2025	11	4	6	30	0	27	0	0	0	0	0	0	0	10.3	0	0
2025	11	4	6	40	0	28	0	0	0	0	0	0	0	10.27	0	0
2025	11	4	6	50	0	27	0	0	0	0	0	0	0	10.25	0	0
2025	11	4	7	0	0	27	0	0	0	0	0	0	0	10.24	0	0
2025	11	4	7	10	0	27	0	0	0	0	0	0	0	10.22	0	0
2025	11	4	7	20	0	27	0	0	0	0	0	0	0	10.2	0	0
2025	11	4	7	30	0	27	0	0	0	0	0	0	0	10.18	0	0
2025	11	4	7	40	0	26	0	0	0	0	0	0	0	10.17	0	0
2025	11	4	7	50	0	28	0	0	0	0	0	0	0	10.15	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	4	8	0	0	28	0	0	0	0	0	0	0	10.13	0	0
2025	11	4	8	10	0	27	0	0	0	0	0	0	0	10.12	0	0
2025	11	4	8	20	0	27	0	0	0	0	0	0	0	10.1	0	0
2025	11	4	8	30	0	28	0	0	0	0	0	0	0	10.09	0	0
2025	11	4	8	40	0	27	0	0	0	0	0	0	0	10.08	0	0
2025	11	4	8	50	0	28	0	0	0	0	0	0	0	10.08	0	0
2025	11	4	9	0	0	27	0	0	0	0	0	0	0	10.08	0	0
2025	11	4	9	10	0	27	0	0	0	0	0	0	0	10.09	0	0
2025	11	4	9	20	0	27	0	0	0	0	0	0	0	10.1	0	0
2025	11	4	9	30	0	27	0	0	0	0	0	0	0	10.11	0	0
2025	11	4	9	40	0	27	0	0	0	0	0	0	0	10.13	0	0
2025	11	4	9	50	0	27	0	0	0	0	0	0	0	10.15	0	0
2025	11	4	10	0	0	27	0	0	0	0	0	0	0	10.17	0	0
2025	11	4	10	10	0	28	0	0	0	0	0	0	0	10.21	0	0
2025	11	4	10	20	0	27	0	0	0	0	0	0	0	10.24	0	0
2025	11	4	10	30	0	28	0	0	0	0	0	0	0	10.29	0	0
2025	11	4	10	40	0	27	0	0	0	0	0	0	0	10.33	0	0
2025	11	4	10	50	0	27	0	0	0	0	0	0	0	10.38	0	0
2025	11	4	11	0	0	27	0	0	0	0	0	0	0	10.43	0	0
2025	11	4	11	10	0	27	0	0	0	0	0	0	0	10.48	0	0
2025	11	4	11	20	0	28	0	0	0	0	0	0	0	10.54	0	0
2025	11	4	11	30	0	28	0	0	0	0	0	0	0	10.6	0	0
2025	11	4	11	40	0	27	0	0	0	0	0	0	0	10.66	0	0
2025	11	4	11	50	0	27	0	0	0	0	0	0	0	10.72	0	0
2025	11	4	12	0	0	28	0	0	0	0	0	0	0	10.78	0	0
2025	11	4	12	10	0	28	0	0	0	0	0	0	0	10.84	0	0
2025	11	4	12	20	0	28	0	0	0	0	0	0	0	10.9	0	0
2025	11	4	12	30	0	27	0	0	0	0	0	0	0	10.97	0	0
2025	11	4	12	40	0	27	0	0	0	0	0	0	0	11.03	0	0
2025	11	4	12	50	0	27	0	0	0	0	0	0	0	11.1	0	0
2025	11	4	13	0	0	27	0	0	0	0	0	0	0	11.15	0	0
2025	11	4	13	10	0	27	0	0	0	0	0	0	0	11.21	0	0
2025	11	4	13	20	0	28	0	0	0	0	0	0	0	11.27	0	0
2025	11	4	13	30	0	27	0	0	0	0	0	0	0	11.32	0	0
2025	11	4	13	40	0	27	0	0	0	0	0	0	0	11.38	0	0
2025	11	4	13	50	0	27	0	0	0	0	0	0	0	11.43	0	0
2025	11	4	14	0	0	27	0	0	0	0	0	0	0	11.48	0	0
2025	11	4	14	10	0	27	0	0	0	0	0	0	0	11.53	0	0
2025	11	4	14	20	0	27	0	0	0	0	0	0	0	11.57	0	0
2025	11	4	14	30	0	27	0	0	0	0	0	0	0	11.62	0	0
2025	11	4	14	40	0	27	0	0	0	0	0	0	0	11.66	0	0
2025	11	4	14	50	0	27	0	0	0	0	0	0	0	11.7	0	0
2025	11	4	15	0	0	27	0	0	0	0	0	0	0	11.74	0	0
2025	11	4	15	10	0	28	0	0	0	0	0	0	0	11.78	0	0
2025	11	4	15	20	0	27	0	0	0	0	0	0	0	11.81	0	0
2025	11	4	15	30	0	27	0	0	0	0	0	0	0	11.85	0	0
2025	11	4	15	40	0	27	0	0	0	0	0	0	0	11.87	0	0
2025	11	4	15	50	0	27	0	0	0	0	0	0	0	11.89	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	4	16	0	0	27	0	0	0	0	0	0	0	11.91	0	0
2025	11	4	16	10	0	27	0	0	0	0	0	0	0	11.93	0	0
2025	11	4	16	20	0	28	0	0	0	0	0	0	0	11.95	0	0
2025	11	4	16	30	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	4	16	40	0	27	0	0	0	0	0	0	0	11.98	0	0
2025	11	4	16	50	0	27	0	0	0	0	0	0	0	12	0	0
2025	11	4	17	0	0	27	0	0	0	0	0	0	0	12.01	0	0
2025	11	4	17	10	0	26	0	0	0	0	0	0	0	12.02	0	0
2025	11	4	17	20	0	27	0	0	0	0	0	0	0	12.03	0	0
2025	11	4	17	30	0	27	0	0	0	0	0	0	0	12.04	0	0
2025	11	4	17	40	0	27	0	0	0	0	0	0	0	12.04	0	0
2025	11	4	17	50	0	27	0	0	0	0	0	0	0	12.04	0	0
2025	11	4	18	0	0	27	0	0	0	0	0	0	0	12.04	0	0
2025	11	4	18	10	0	27	0	0	0	0	0	0	0	12.03	0	0
2025	11	4	18	20	0	27	0	0	0	0	0	0	0	12.03	0	0
2025	11	4	18	30	0	27	0	0	0	0	0	0	0	12.02	0	0
2025	11	4	18	40	0	27	0	0	0	0	0	0	0	12	0	0
2025	11	4	18	50	0	27	0	0	0	0	0	0	0	11.99	0	0
2025	11	4	19	0	0	26	0	0	0	0	0	0	0	11.97	0	0
2025	11	4	19	10	0	27	0	0	0	0	0	0	0	11.95	0	0
2025	11	4	19	20	0	27	0	0	0	0	0	0	0	11.93	0	0
2025	11	4	19	30	0	26	0	0	0	0	0	0	0	11.9	0	0
2025	11	4	19	40	0	27	0	0	0	0	0	0	0	11.88	0	0
2025	11	4	19	50	0	27	0	0	0	0	0	0	0	11.85	0	0
2025	11	4	20	0	0	27	0	0	0	0	0	0	0	11.81	0	0
2025	11	4	20	10	0	27	0	0	0	0	0	0	0	11.78	0	0
2025	11	4	20	20	0	27	0	0	0	0	0	0	0	11.74	0	0
2025	11	4	20	30	0	27	0	0	0	0	0	0	0	11.71	0	0
2025	11	4	20	40	0	28	0	0	0	0	0	0	0	11.67	0	0
2025	11	4	20	50	0	27	0	0	0	0	0	0	0	11.64	0	0
2025	11	4	21	0	0	28	0	0	0	0	0	0	0	11.61	0	0
2025	11	4	21	10	0	27	0	0	0	0	0	0	0	11.57	0	0
2025	11	4	21	20	0	27	0	0	0	0	0	0	0	11.54	0	0
2025	11	4	21	30	0	28	0	0	0	0	0	0	0	11.5	0	0
2025	11	4	21	40	0	27	0	0	0	0	0	0	0	11.46	0	0
2025	11	4	21	50	0	27	0	0	0	0	0	0	0	11.43	0	0
2025	11	4	22	0	0	27	0	0	0	0	0	0	0	11.4	0	0
2025	11	4	22	10	0	27	0	0	0	0	0	0	0	11.37	0	0
2025	11	4	22	20	0	27	0	0	0	0	0	0	0	11.33	0	0
2025	11	4	22	30	0	27	0	0	0	0	0	0	0	11.29	0	0
2025	11	4	22	40	0	27	0	0	0	0	0	0	0	11.26	0	0
2025	11	4	22	50	0	27	0	0	0	0	0	0	0	11.23	0	0
2025	11	4	23	0	0	27	0	0	0	0	0	0	0	11.2	0	0
2025	11	4	23	10	0	27	0	0	0	0	0	0	0	11.17	0	0
2025	11	4	23	20	0	28	0	0	0	0	0	0	0	11.13	0	0
2025	11	4	23	30	0	28	0	0	0	0	0	0	0	11.11	0	0
2025	11	4	23	40	0	27	0	0	0	0	0	0	0	11.07	0	0
2025	11	4	23	50	0	27	0	0	0	0	0	0	0	11.04	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	5	0	0	0	27	0	0	0	0	0	0	0	11.01	0	0
2025	11	5	0	10	0	27	0	0	0	0	0	0	0	10.98	0	0
2025	11	5	0	20	0	27	0	0	0	0	0	0	0	10.94	0	0
2025	11	5	0	30	0	27	0	0	0	0	0	0	0	10.91	0	0
2025	11	5	0	40	0	27	0	0	0	0	0	0	0	10.88	0	0
2025	11	5	0	50	0	27	0	0	0	0	0	0	0	10.84	0	0
2025	11	5	1	0	0	28	0	0	0	0	0	0	0	10.82	0	0
2025	11	5	1	10	0	27	0	0	0	0	0	0	0	10.79	0	0
2025	11	5	1	20	0	27	0	0	0	0	0	0	0	10.76	0	0
2025	11	5	1	30	0	27	0	0	0	0	0	0	0	10.73	0	0
2025	11	5	1	40	0	27	0	0	0	0	0	0	0	10.7	0	0
2025	11	5	1	50	0	28	0	0	0	0	0	0	0	10.67	0	0
2025	11	5	2	0	0	27	0	0	0	0	0	0	0	10.64	0	0
2025	11	5	2	10	0	27	0	0	0	0	0	0	0	10.61	0	0
2025	11	5	2	20	0	27	0	0	0	0	0	0	0	10.58	0	0
2025	11	5	2	30	0	27	0	0	0	0	0	0	0	10.55	0	0
2025	11	5	2	40	0	27	0	0	0	0	0	0	0	10.53	0	0
2025	11	5	2	50	0	27	0	0	0	0	0	0	0	10.5	0	0
2025	11	5	3	0	0	27	0	0	0	0	0	0	0	10.47	0	0
2025	11	5	3	10	0	28	0	0	0	0	0	0	0	10.45	0	0
2025	11	5	3	20	0	27	0	0	0	0	0	0	0	10.43	0	0
2025	11	5	3	30	0	27	0	0	0	0	0	0	0	10.41	0	0
2025	11	5	3	40	0	26	0	0	0	0	0	0	0	10.39	0	0
2025	11	5	3	50	0	27	0	0	0	0	0	0	0	10.37	0	0
2025	11	5	4	0	0	27	0	0	0	0	0	0	0	10.36	0	0
2025	11	5	4	10	0	27	0	0	0	0	0	0	0	10.34	0	0
2025	11	5	4	20	0	26	0	0	0	0	0	0	0	10.33	0	0
2025	11	5	4	30	0	27	0	0	0	0	0	0	0	10.32	0	0
2025	11	5	4	40	0	28	0	0	0	0	0	0	0	10.3	0	0
2025	11	5	4	50	0	27	0	0	0	0	0	0	0	10.28	0	0
2025	11	5	5	0	0	27	0	0	0	0	0	0	0	10.27	0	0
2025	11	5	5	10	0	27	0	0	0	0	0	0	0	10.25	0	0
2025	11	5	5	20	0	27	0	0	0	0	0	0	0	10.24	0	0
2025	11	5	5	30	0	27	0	0	0	0	0	0	0	10.23	0	0
2025	11	5	5	40	0	28	0	0	0	0	0	0	0	10.22	0	0
2025	11	5	5	50	0	28	0	0	0	0	0	0	0	10.2	0	0
2025	11	5	6	0	0	28	0	0	0	0	0	0	0	10.18	0	0
2025	11	5	6	10	0	27	0	0	0	0	0	0	0	10.17	0	0
2025	11	5	6	20	0	27	0	0	0	0	0	0	0	10.15	0	0
2025	11	5	6	30	0	27	0	0	0	0	0	0	0	10.13	0	0
2025	11	5	6	40	0	27	0	0	0	0	0	0	0	10.12	0	0
2025	11	5	6	50	0	27	0	0	0	0	0	0	0	10.1	0	0
2025	11	5	7	0	0	27	0	0	0	0	0	0	0	10.09	0	0
2025	11	5	7	10	0	27	0	0	0	0	0	0	0	10.07	0	0
2025	11	5	7	20	0	27	0	0	0	0	0	0	0	10.06	0	0
2025	11	5	7	30	0	27	0	0	0	0	0	0	0	10.04	0	0
2025	11	5	7	40	0	27	0	0	0	0	0	0	0	10.02	0	0
2025	11	5	7	50	0	28	0	0	0	0	0	0	0	10.02	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	5	8	0	0	28	0	0	0	0	0	0	0	10	0	0
2025	11	5	8	10	0	27	0	0	0	0	0	0	0	10	0	0
2025	11	5	8	20	0	27	0	0	0	0	0	0	0	9.99	0	0
2025	11	5	8	30	0	27	0	0	0	0	0	0	0	9.98	0	0
2025	11	5	8	40	0	27	0	0	0	0	0	0	0	9.99	0	0
2025	11	5	8	50	0	27	0	0	0	0	0	0	0	9.99	0	0
2025	11	5	9	0	0	26	0	0	0	0	0	0	0	10.01	0	0
2025	11	5	9	10	0	27	0	0	0	0	0	0	0	10.02	0	0
2025	11	5	9	20	0	28	0	0	0	0	0	0	0	10.04	0	0
2025	11	5	9	30	0	27	0	0	0	0	0	0	0	10.06	0	0
2025	11	5	9	40	0	28	0	0	0	0	0	0	0	10.09	0	0
2025	11	5	9	50	0	27	0	0	0	0	0	0	0	10.12	0	0
2025	11	5	10	0	0	27	0	0	0	0	0	0	0	10.16	0	0
2025	11	5	10	10	0	27	0	0	0	0	0	0	0	10.2	0	0
2025	11	5	10	20	0	27	0	0	0	0	0	0	0	10.24	0	0
2025	11	5	10	30	0	27	0	0	0	0	0	0	0	10.28	0	0
2025	11	5	10	40	0	27	0	0	0	0	0	0	0	10.32	0	0
2025	11	5	10	50	0	27	0	0	0	0	0	0	0	10.37	0	0
2025	11	5	11	0	0	28	0	0	0	0	0	0	0	10.43	0	0
2025	11	5	11	10	0	27	0	0	0	0	0	0	0	10.48	0	0
2025	11	5	11	20	0	27	0	0	0	0	0	0	0	10.52	0	0
2025	11	5	11	30	0	28	0	0	0	0	0	0	0	10.58	0	0
2025	11	5	11	40	0	27	0	0	0	0	0	0	0	10.64	0	0
2025	11	5	11	50	0	27	0	0	0	0	0	0	0	10.7	0	0
2025	11	5	12	0	0	27	0	0	0	0	0	0	0	10.74	0	0
2025	11	5	12	10	0	28	0	0	0	0	0	0	0	10.79	0	0
2025	11	5	12	20	0	27	0	0	0	0	0	0	0	10.85	0	0
2025	11	5	12	30	0	27	0	0	0	0	0	0	0	10.91	0	0
2025	11	5	12	40	0	27	0	0	0	0	0	0	0	10.98	0	0
2025	11	5	12	50	0	27	0	0	0	0	0	0	0	11.04	0	0
2025	11	5	13	0	0	27	0	0	0	0	0	0	0	11.09	0	0
2025	11	5	13	10	0	27	0	0	0	0	0	0	0	11.15	0	0
2025	11	5	13	20	0	27	0	0	0	0	0	0	0	11.21	0	0
2025	11	5	13	30	0	27	0	0	0	0	0	0	0	11.26	0	0
2025	11	5	13	40	0	27	0	0	0	0	0	0	0	11.31	0	0
2025	11	5	13	50	0	27	0	0	0	0	0	0	0	11.36	0	0
2025	11	5	14	0	0	27	0	0	0	0	0	0	0	11.42	0	0
2025	11	5	14	10	0	28	0	0	0	0	0	0	0	11.48	0	0
2025	11	5	14	20	0	27	0	0	0	0	0	0	0	11.53	0	0
2025	11	5	14	30	0	27	0	0	0	0	0	0	0	11.58	0	0
2025	11	5	14	40	0	27	0	0	0	0	0	0	0	11.63	0	0
2025	11	5	14	50	0	28	0	0	0	0	0	0	0	11.68	0	0
2025	11	5	15	0	0	28	0	0	0	0	0	0	0	11.73	0	0
2025	11	5	15	10	0	27	0	0	0	0	0	0	0	11.77	0	0
2025	11	5	15	20	0	26	0	0	0	0	0	0	0	11.81	0	0
2025	11	5	15	30	0	28	0	0	0	0	0	0	0	11.84	0	0
2025	11	5	15	40	0	26	0	0	0	0	0	0	0	11.88	0	0
2025	11	5	15	50	0	27	0	0	0	0	0	0	0	11.92	0	0

Mazourka (0354)

	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	5	16	0	0	27	0	0	0	0	0	0	0	11.95	0	0
2025	11	5	16	10	0	27	0	0	0	0	0	0	0	11.99	0	0
2025	11	5	16	20	0	27	0	0	0	0	0	0	0	12.01	0	0
2025	11	5	16	30	0	27	0	0	0	0	0	0	0	12.05	0	0
2025	11	5	16	40	0	27	0	0	0	0	0	0	0	12.07	0	0
2025	11	5	16	50	0	28	0	0	0	0	0	0	0	12.1	0	0
2025	11	5	17	0	0	27	0	0	0	0	0	0	0	12.13	0	0
2025	11	5	17	10	0	27	0	0	0	0	0	0	0	12.15	0	0
2025	11	5	17	20	0	27	0	0	0	0	0	0	0	12.18	0	0
2025	11	5	17	30	0	27	0	0	0	0	0	0	0	12.2	0	0
2025	11	5	17	40	0	27	0	0	0	0	0	0	0	12.21	0	0
2025	11	5	17	50	0	27	0	0	0	0	0	0	0	12.23	0	0
2025	11	5	18	0	0	27	0	0	0	0	0	0	0	12.24	0	0
2025	11	5	18	10	0	27	0	0	0	0	0	0	0	12.24	0	0
2025	11	5	18	20	0	27	0	0	0	0	0	0	0	12.25	0	0
2025	11	5	18	30	0	27	0	0	0	0	0	0	0	12.25	0	0
2025	11	5	18	40	0	27	0	0	0	0	0	0	0	12.26	0	0
2025	11	5	18	50	0	27	0	0	0	0	0	0	0	12.25	0	0
2025	11	5	19	0	0	27	0	0	0	0	0	0	0	12.25	0	0
2025	11	5	19	10	0	27	0	0	0	0	0	0	0	12.24	0	0
2025	11	5	19	20	0	26	0	0	0	0	0	0	0	12.23	0	0
2025	11	5	19	30	0	27	0	0	0	0	0	0	0	12.22	0	0
2025	11	5	19	40	0	27	0	0	0	0	0	0	0	12.22	0	0
2025	11	5	19	50	0	27	0	0	0	0	0	0	0	12.2	0	0
2025	11	5	20	0	0	27	0	0	0	0	0	0	0	12.2	0	0
2025	11	5	20	10	0	27	0	0	0	0	0	0	0	12.19	0	0
2025	11	5	20	20	0	27	0	0	0	0	0	0	0	12.18	0	0
2025	11	5	20	30	0	27	0	0	0	0	0	0	0	12.16	0	0
2025	11	5	20	40	0	27	0	0	0	0	0	0	0	12.15	0	0
2025	11	5	20	50	0	26	0	0	0	0	0	0	0	12.14	0	0
2025	11	5	21	0	0	27	0	0	0	0	0	0	0	12.13	0	0
2025	11	5	21	10	0	27	0	0	0	0	0	0	0	12.12	0	0
2025	11	5	21	20	0	27	0	0	0	0	0	0	0	12.1	0	0
2025	11	5	21	30	0	27	0	0	0	0	0	0	0	12.09	0	0
2025	11	5	21	40	0	26	0	0	0	0	0	0	0	12.07	0	0
2025	11	5	21	50	0	27	0	0	0	0	0	0	0	12.06	0	0
2025	11	5	22	0	0	27	0	0	0	0	0	0	0	12.04	0	0
2025	11	5	22	10	0	27	0	0	0	0	0	0	0	12.02	0	0
2025	11	5	22	20	0	27	0	0	0	0	0	0	0	12.01	0	0
2025	11	5	22	30	0	27	0	0	0	0	0	0	0	12	0	0
2025	11	5	22	40	0	27	0	0	0	0	0	0	0	11.99	0	0
2025	11	5	22	50	0	26	0	0	0	0	0	0	0	11.97	0	0
2025	11	5	23	0	0	27	0	0	0	0	0	0	0	11.96	0	0
2025	11	5	23	10	0	27	0	0	0	0	0	0	0	11.94	0	0
2025	11	5	23	20	0	27	0	0	0	0	0	0	0	11.93	0	0
2025	11	5	23	30	0	27	0	0	0	0	0	0	0	11.91	0	0
2025	11	5	23	40	0	27	0	0	0	0	0	0	0	11.9	0	0
2025	11	5	23	50	0	28	0	0	0	0	0	0	0	11.88	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	6	0	0	0	26	0	0	0	0	0	0	0	11.87	0	0
2025	11	6	0	10	0	27	0	0	0	0	0	0	0	11.85	0	0
2025	11	6	0	20	0	27	0	0	0	0	0	0	0	11.83	0	0
2025	11	6	0	30	0	28	0	0	0	0	0	0	0	11.82	0	0
2025	11	6	0	40	0	27	0	0	0	0	0	0	0	11.8	0	0
2025	11	6	0	50	0	26	0	0	0	0	0	0	0	11.78	0	0
2025	11	6	1	0	0	27	0	0	0	0	0	0	0	11.76	0	0
2025	11	6	1	10	0	27	0	0	0	0	0	0	0	11.75	0	0
2025	11	6	1	20	0	27	0	0	0	0	0	0	0	11.73	0	0
2025	11	6	1	30	0	27	0	0	0	0	0	0	0	11.72	0	0
2025	11	6	1	40	0	27	0	0	0	0	0	0	0	11.71	0	0
2025	11	6	1	50	0	27	0	0	0	0	0	0	0	11.69	0	0
2025	11	6	2	0	0	27	0	0	0	0	0	0	0	11.69	0	0
2025	11	6	2	10	0	27	0	0	0	0	0	0	0	11.67	0	0
2025	11	6	2	20	0	27	0	0	0	0	0	0	0	11.66	0	0
2025	11	6	2	30	0	27	0	0	0	0	0	0	0	11.64	0	0
2025	11	6	2	40	0	27	0	0	0	0	0	0	0	11.63	0	0
2025	11	6	2	50	0	27	0	0	0	0	0	0	0	11.62	0	0
2025	11	6	3	0	0	27	0	0	0	0	0	0	0	11.61	0	0
2025	11	6	3	10	0	27	0	0	0	0	0	0	0	11.59	0	0
2025	11	6	3	20	0	27	0	0	0	0	0	0	0	11.58	0	0
2025	11	6	3	30	0	27	0	0	0	0	0	0	0	11.57	0	0
2025	11	6	3	40	0	27	0	0	0	0	0	0	0	11.55	0	0
2025	11	6	3	50	0	27	0	0	0	0	0	0	0	11.54	0	0
2025	11	6	4	0	0	27	0	0	0	0	0	0	0	11.53	0	0
2025	11	6	4	10	0	27	0	0	0	0	0	0	0	11.51	0	0
2025	11	6	4	20	0	27	0	0	0	0	0	0	0	11.5	0	0
2025	11	6	4	30	0	27	0	0	0	0	0	0	0	11.49	0	0
2025	11	6	4	40	0	27	0	0	0	0	0	0	0	11.47	0	0
2025	11	6	4	50	0	26	0	0	0	0	0	0	0	11.47	0	0
2025	11	6	5	0	0	27	0	0	0	0	0	0	0	11.45	0	0
2025	11	6	5	10	0	27	0	0	0	0	0	0	0	11.44	0	0
2025	11	6	5	20	0	27	0	0	0	0	0	0	0	11.43	0	0
2025	11	6	5	30	0	27	0	0	0	0	0	0	0	11.41	0	0
2025	11	6	5	40	0	27	0	0	0	0	0	0	0	11.4	0	0
2025	11	6	5	50	0	27	0	0	0	0	0	0	0	11.38	0	0
2025	11	6	6	0	0	27	0	0	0	0	0	0	0	11.37	0	0
2025	11	6	6	10	0	28	0	0	0	0	0	0	0	11.36	0	0
2025	11	6	6	20	0	27	0	0	0	0	0	0	0	11.34	0	0
2025	11	6	6	30	0	28	0	0	0	0	0	0	0	11.32	0	0
2025	11	6	6	40	0	27	0	0	0	0	0	0	0	11.31	0	0
2025	11	6	6	50	0	27	0	0	0	0	0	0	0	11.29	0	0
2025	11	6	7	0	0	27	0	0	0	0	0	0	0	11.27	0	0
2025	11	6	7	10	0	27	0	0	0	0	0	0	0	11.25	0	0
2025	11	6	7	20	0	27	0	0	0	0	0	0	0	11.23	0	0
2025	11	6	7	30	0	27	0	0	0	0	0	0	0	11.21	0	0
2025	11	6	7	40	0	27	0	0	0	0	0	0	0	11.19	0	0
2025	11	6	7	50	0	27	0	0	0	0	0	0	0	11.17	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	6	8	0	0	27	0	0	0	0	0	0	0	11.15	0	0
2025	11	6	8	10	0	27	0	0	0	0	0	0	0	11.13	0	0
2025	11	6	8	20	0	27	0	0	0	0	0	0	0	11.11	0	0
2025	11	6	8	30	0	27	0	0	0	0	0	0	0	11.1	0	0
2025	11	6	8	40	0	27	0	0	0	0	0	0	0	11.09	0	0
2025	11	6	8	50	0	27	0	0	0	0	0	0	0	11.08	0	0
2025	11	6	9	0	0	27	0	0	0	0	0	0	0	11.08	0	0
2025	11	6	9	10	0	27	0	0	0	0	0	0	0	11.08	0	0
2025	11	6	9	20	0	28	0	0	0	0	0	0	0	11.08	0	0
2025	11	6	9	30	0	27	0	0	0	0	0	0	0	11.09	0	0
2025	11	6	9	40	0	27	0	0	0	0	0	0	0	11.11	0	0
2025	11	6	9	50	0	27	0	0	0	0	0	0	0	11.12	0	0
2025	11	6	10	0	0	28	0	0	0	0	0	0	0	11.14	0	0
2025	11	6	10	10	0	27	0	0	0	0	0	0	0	11.17	0	0
2025	11	6	10	20	0	27	0	0	0	0	0	0	0	11.2	0	0
2025	11	6	10	30	0	27	0	0	0	0	0	0	0	11.23	0	0
2025	11	6	10	40	0	27	0	0	0	0	0	0	0	11.27	0	0
2025	11	6	10	50	0	28	0	0	0	0	0	0	0	11.3	0	0
2025	11	6	11	0	0	27	0	0	0	0	0	0	0	11.34	0	0
2025	11	6	11	10	0	27	0	0	0	0	0	0	0	11.38	0	0
2025	11	6	11	20	0	26	0	0	0	0	0	0	0	11.43	0	0
2025	11	6	11	30	0	28	0	0	0	0	0	0	0	11.48	0	0
2025	11	6	11	40	0	27	0	0	0	0	0	0	0	11.53	0	0
2025	11	6	11	50	0	27	0	0	0	0	0	0	0	11.57	0	0
2025	11	6	12	0	0	27	0	0	0	0	0	0	0	11.62	0	0
2025	11	6	12	10	0	27	0	0	0	0	0	0	0	11.67	0	0
2025	11	6	12	20	0	27	0	0	0	0	0	0	0	11.72	0	0
2025	11	6	12	30	0	27	0	0	0	0	0	0	0	11.78	0	0
2025	11	6	12	40	0	27	0	0	0	0	0	0	0	11.82	0	0
2025	11	6	12	50	0	27	0	0	0	0	0	0	0	11.88	0	0
2025	11	6	13	0	0	27	0	0	0	0	0	0	0	11.92	0	0
2025	11	6	13	10	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	6	13	20	0	27	0	0	0	0	0	0	0	12.02	0	0
2025	11	6	13	30	0	28	0	0	0	0	0	0	0	12.07	0	0
2025	11	6	13	40	0	26	0	0	0	0	0	0	0	12.12	0	0
2025	11	6	13	50	0	27	0	0	0	0	0	0	0	12.17	0	0
2025	11	6	14	0	0	27	0	0	0	0	0	0	0	12.21	0	0
2025	11	6	14	10	0	27	0	0	0	0	0	0	0	12.26	0	0
2025	11	6	14	20	0	27	0	0	0	0	0	0	0	12.3	0	0
2025	11	6	14	30	0	27	0	0	0	0	0	0	0	12.35	0	0
2025	11	6	14	40	0	27	0	0	0	0	0	0	0	12.39	0	0
2025	11	6	14	50	0	26	0	0	0	0	0	0	0	12.44	0	0
2025	11	6	15	0	0	27	0	0	0	0	0	0	0	12.48	0	0
2025	11	6	15	10	0	27	0	0	0	0	0	0	0	12.52	0	0
2025	11	6	15	20	0	27	0	0	0	0	0	0	0	12.55	0	0
2025	11	6	15	30	0	27	0	0	0	0	0	0	0	12.59	0	0
2025	11	6	15	40	0	27	0	0	0	0	0	0	0	12.62	0	0
2025	11	6	15	50	0	28	0	0	0	0	0	0	0	12.65	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	6	16	0	0	27	0	0	0	0	0	0	0	12.68	0	0
2025	11	6	16	10	0	27	0	0	0	0	0	0	0	12.7	0	0
2025	11	6	16	20	0	27	0	0	0	0	0	0	0	12.72	0	0
2025	11	6	16	30	0	27	0	0	0	0	0	0	0	12.74	0	0
2025	11	6	16	40	0	27	0	0	0	0	0	0	0	12.75	0	0
2025	11	6	16	50	0	27	0	0	0	0	0	0	0	12.77	0	0
2025	11	6	17	0	0	27	0	0	0	0	0	0	0	12.78	0	0
2025	11	6	17	10	0	27	0	0	0	0	0	0	0	12.79	0	0
2025	11	6	17	20	0	26	0	0	0	0	0	0	0	12.8	0	0
2025	11	6	17	30	0	27	0	0	0	0	0	0	0	12.8	0	0
2025	11	6	17	40	0	27	0	0	0	0	0	0	0	12.8	0	0
2025	11	6	17	50	0	26	0	0	0	0	0	0	0	12.79	0	0
2025	11	6	18	0	0	27	0	0	0	0	0	0	0	12.78	0	0
2025	11	6	18	10	0	27	0	0	0	0	0	0	0	12.77	0	0
2025	11	6	18	20	0	27	0	0	0	0	0	0	0	12.75	0	0
2025	11	6	18	30	0	27	0	0	0	0	0	0	0	12.74	0	0
2025	11	6	18	40	0	27	0	0	0	0	0	0	0	12.71	0	0
2025	11	6	18	50	0	27	0	0	0	0	0	0	0	12.69	0	0
2025	11	6	19	0	0	26	0	0	0	0	0	0	0	12.66	0	0
2025	11	6	19	10	0	27	0	0	0	0	0	0	0	12.62	0	0
2025	11	6	19	20	0	26	0	0	0	0	0	0	0	12.59	0	0
2025	11	6	19	30	0	28	0	0	0	0	0	0	0	12.55	0	0
2025	11	6	19	40	0	27	0	0	0	0	0	0	0	12.51	0	0
2025	11	6	19	50	0	27	0	0	0	0	0	0	0	12.47	0	0
2025	11	6	20	0	0	27	0	0	0	0	0	0	0	12.43	0	0
2025	11	6	20	10	0	27	0	0	0	0	0	0	0	12.39	0	0
2025	11	6	20	20	0	27	0	0	0	0	0	0	0	12.35	0	0
2025	11	6	20	30	0	28	0	0	0	0	0	0	0	12.31	0	0
2025	11	6	20	40	0	27	0	0	0	0	0	0	0	12.26	0	0
2025	11	6	20	50	0	26	0	0	0	0	0	0	0	12.23	0	0
2025	11	6	21	0	0	27	0	0	0	0	0	0	0	12.18	0	0
2025	11	6	21	10	0	27	0	0	0	0	0	0	0	12.13	0	0
2025	11	6	21	20	0	27	0	0	0	0	0	0	0	12.09	0	0
2025	11	6	21	30	0	27	0	0	0	0	0	0	0	12.05	0	0
2025	11	6	21	40	0	27	0	0	0	0	0	0	0	12.01	0	0
2025	11	6	21	50	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	6	22	0	0	27	0	0	0	0	0	0	0	11.93	0	0
2025	11	6	22	10	0	26	0	0	0	0	0	0	0	11.89	0	0
2025	11	6	22	20	0	26	0	0	0	0	0	0	0	11.86	0	0
2025	11	6	22	30	0	27	0	0	0	0	0	0	0	11.82	0	0
2025	11	6	22	40	0	27	0	0	0	0	0	0	0	11.78	0	0
2025	11	6	22	50	0	28	0	0	0	0	0	0	0	11.75	0	0
2025	11	6	23	0	0	27	0	0	0	0	0	0	0	11.71	0	0
2025	11	6	23	10	0	27	0	0	0	0	0	0	0	11.67	0	0
2025	11	6	23	20	0	27	0	0	0	0	0	0	0	11.64	0	0
2025	11	6	23	30	0	27	0	0	0	0	0	0	0	11.6	0	0
2025	11	6	23	40	0	28	0	0	0	0	0	0	0	11.56	0	0
2025	11	6	23	50	0	27	0	0	0	0	0	0	0	11.52	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	7	0	0	0	27	0	0	0	0	0	0	0	11.49	0	0
2025	11	7	0	10	0	28	0	0	0	0	0	0	0	11.45	0	0
2025	11	7	0	20	0	27	0	0	0	0	0	0	0	11.42	0	0
2025	11	7	0	30	0	27	0	0	0	0	0	0	0	11.39	0	0
2025	11	7	0	40	0	27	0	0	0	0	0	0	0	11.35	0	0
2025	11	7	0	50	0	27	0	0	0	0	0	0	0	11.32	0	0
2025	11	7	1	0	0	27	0	0	0	0	0	0	0	11.29	0	0
2025	11	7	1	10	0	27	0	0	0	0	0	0	0	11.25	0	0
2025	11	7	1	20	0	27	0	0	0	0	0	0	0	11.22	0	0
2025	11	7	1	30	0	27	0	0	0	0	0	0	0	11.19	0	0
2025	11	7	1	40	0	28	0	0	0	0	0	0	0	11.16	0	0
2025	11	7	1	50	0	27	0	0	0	0	0	0	0	11.13	0	0
2025	11	7	2	0	0	27	0	0	0	0	0	0	0	11.1	0	0
2025	11	7	2	10	0	27	0	0	0	0	0	0	0	11.07	0	0
2025	11	7	2	20	0	28	0	0	0	0	0	0	0	11.04	0	0
2025	11	7	2	30	0	27	0	0	0	0	0	0	0	11.01	0	0
2025	11	7	2	40	0	28	0	0	0	0	0	0	0	10.99	0	0
2025	11	7	2	50	0	27	0	0	0	0	0	0	0	10.96	0	0
2025	11	7	3	0	0	27	0	0	0	0	0	0	0	10.94	0	0
2025	11	7	3	10	0	28	0	0	0	0	0	0	0	10.92	0	0
2025	11	7	3	20	0	27	0	0	0	0	0	0	0	10.89	0	0
2025	11	7	3	30	0	27	0	0	0	0	0	0	0	10.87	0	0
2025	11	7	3	40	0	27	0	0	0	0	0	0	0	10.85	0	0
2025	11	7	3	50	0	27	0	0	0	0	0	0	0	10.83	0	0
2025	11	7	4	0	0	27	0	0	0	0	0	0	0	10.81	0	0
2025	11	7	4	10	0	27	0	0	0	0	0	0	0	10.79	0	0
2025	11	7	4	20	0	27	0	0	0	0	0	0	0	10.77	0	0
2025	11	7	4	30	0	27	0	0	0	0	0	0	0	10.75	0	0
2025	11	7	4	40	0	27	0	0	0	0	0	0	0	10.74	0	0
2025	11	7	4	50	0	27	0	0	0	0	0	0	0	10.72	0	0
2025	11	7	5	0	0	27	0	0	0	0	0	0	0	10.7	0	0
2025	11	7	5	10	0	28	0	0	0	0	0	0	0	10.69	0	0
2025	11	7	5	20	0	27	0	0	0	0	0	0	0	10.67	0	0
2025	11	7	5	30	0	27	0	0	0	0	0	0	0	10.66	0	0
2025	11	7	5	40	0	27	0	0	0	0	0	0	0	10.64	0	0
2025	11	7	5	50	0	27	0	0	0	0	0	0	0	10.62	0	0
2025	11	7	6	0	0	27	0	0	0	0	0	0	0	10.6	0	0
2025	11	7	6	10	0	28	0	0	0	0	0	0	0	10.59	0	0
2025	11	7	6	20	0	27	0	0	0	0	0	0	0	10.57	0	0
2025	11	7	6	30	0	28	0	0	0	0	0	0	0	10.56	0	0
2025	11	7	6	40	0	27	0	0	0	0	0	0	0	10.54	0	0
2025	11	7	6	50	0	27	0	0	0	0	0	0	0	10.52	0	0
2025	11	7	7	0	0	27	0	0	0	0	0	0	0	10.5	0	0
2025	11	7	7	10	0	27	0	0	0	0	0	0	0	10.48	0	0
2025	11	7	7	20	0	28	0	0	0	0	0	0	0	10.47	0	0
2025	11	7	7	30	0	27	0	0	0	0	0	0	0	10.45	0	0
2025	11	7	7	40	0	27	0	0	0	0	0	0	0	10.43	0	0
2025	11	7	7	50	0	27	0	0	0	0	0	0	0	10.41	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	7	8	0	0	28	0	0	0	0	0	0	0	10.39	0	0
2025	11	7	8	10	0	27	0	0	0	0	0	0	0	10.37	0	0
2025	11	7	8	20	0	27	0	0	0	0	0	0	0	10.35	0	0
2025	11	7	8	30	0	27	0	0	0	0	0	0	0	10.34	0	0
2025	11	7	8	40	0	27	0	0	0	0	0	0	0	10.33	0	0
2025	11	7	8	50	0	27	0	0	0	0	0	0	0	10.32	0	0
2025	11	7	9	0	0	27	0	0	0	0	0	0	0	10.32	0	0
2025	11	7	9	10	0	27	0	0	0	0	0	0	0	10.32	0	0
2025	11	7	9	20	0	27	0	0	0	0	0	0	0	10.32	0	0
2025	11	7	9	30	0	28	0	0	0	0	0	0	0	10.33	0	0
2025	11	7	9	40	0	27	0	0	0	0	0	0	0	10.34	0	0
2025	11	7	9	50	0	28	0	0	0	0	0	0	0	10.35	0	0
2025	11	7	10	0	0	27	0	0	0	0	0	0	0	10.37	0	0
2025	11	7	10	10	0	27	0	0	0	0	0	0	0	10.39	0	0
2025	11	7	10	20	0	27	0	0	0	0	0	0	0	10.42	0	0
2025	11	7	10	30	0	27	0	0	0	0	0	0	0	10.45	0	0
2025	11	7	10	40	0	27	0	0	0	0	0	0	0	10.48	0	0
2025	11	7	10	50	0	28	0	0	0	0	0	0	0	10.51	0	0
2025	11	7	11	0	0	27	0	0	0	0	0	0	0	10.55	0	0
2025	11	7	11	10	0	28	0	0	0	0	0	0	0	10.59	0	0
2025	11	7	11	20	0	27	0	0	0	0	0	0	0	10.64	0	0
2025	11	7	11	30	0	28	0	0	0	0	0	0	0	10.68	0	0
2025	11	7	11	40	0	27	0	0	0	0	0	0	0	10.73	0	0
2025	11	7	11	50	0	27	0	0	0	0	0	0	0	10.79	0	0
2025	11	7	12	0	0	28	0	0	0	0	0	0	0	10.84	0	0
2025	11	7	12	10	0	27	0	0	0	0	0	0	0	10.9	0	0
2025	11	7	12	20	0	27	0	0	0	0	0	0	0	10.96	0	0
2025	11	7	12	30	0	27	0	0	0	0	0	0	0	11.01	0	0
2025	11	7	12	40	0	28	0	0	0	0	0	0	0	11.07	0	0
2025	11	7	12	50	0	27	0	0	0	0	0	0	0	11.12	0	0
2025	11	7	13	0	0	27	0	0	0	0	0	0	0	11.17	0	0
2025	11	7	13	10	0	28	0	0	0	0	0	0	0	11.22	0	0
2025	11	7	13	20	0	27	0	0	0	0	0	0	0	11.28	0	0
2025	11	7	13	30	0	27	0	0	0	0	0	0	0	11.33	0	0
2025	11	7	13	40	0	28	0	0	0	0	0	0	0	11.38	0	0
2025	11	7	13	50	0	27	0	0	0	0	0	0	0	11.43	0	0
2025	11	7	14	0	0	27	0	0	0	0	0	0	0	11.49	0	0
2025	11	7	14	10	0	27	0	0	0	0	0	0	0	11.53	0	0
2025	11	7	14	20	0	27	0	0	0	0	0	0	0	11.58	0	0
2025	11	7	14	30	0	27	0	0	0	0	0	0	0	11.63	0	0
2025	11	7	14	40	0	27	0	0	0	0	0	0	0	11.67	0	0
2025	11	7	14	50	0	27	0	0	0	0	0	0	0	11.72	0	0
2025	11	7	15	0	0	27	0	0	0	0	0	0	0	11.75	0	0
2025	11	7	15	10	0	27	0	0	0	0	0	0	0	11.79	0	0
2025	11	7	15	20	0	28	0	0	0	0	0	0	0	11.82	0	0
2025	11	7	15	30	0	27	0	0	0	0	0	0	0	11.86	0	0
2025	11	7	15	40	0	27	0	0	0	0	0	0	0	11.88	0	0
2025	11	7	15	50	0	28	0	0	0	0	0	0	0	11.91	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	7	16	0	0	27	0	0	0	0	0	0	0	11.94	0	0
2025	11	7	16	10	0	28	0	0	0	0	0	0	0	11.96	0	0
2025	11	7	16	20	0	27	0	0	0	0	0	0	0	11.98	0	0
2025	11	7	16	30	0	27	0	0	0	0	0	0	0	12	0	0
2025	11	7	16	40	0	26	0	0	0	0	0	0	0	12.02	0	0
2025	11	7	16	50	0	28	0	0	0	0	0	0	0	12.03	0	0
2025	11	7	17	0	0	27	0	0	0	0	0	0	0	12.05	0	0
2025	11	7	17	10	0	27	0	0	0	0	0	0	0	12.06	0	0
2025	11	7	17	20	0	27	0	0	0	0	0	0	0	12.07	0	0
2025	11	7	17	30	0	27	0	0	0	0	0	0	0	12.08	0	0
2025	11	7	17	40	0	27	0	0	0	0	0	0	0	12.08	0	0
2025	11	7	17	50	0	27	0	0	0	0	0	0	0	12.08	0	0
2025	11	7	18	0	0	27	0	0	0	0	0	0	0	12.08	0	0
2025	11	7	18	10	0	27	0	0	0	0	0	0	0	12.07	0	0
2025	11	7	18	20	0	27	0	0	0	0	0	0	0	12.06	0	0
2025	11	7	18	30	0	27	0	0	0	0	0	0	0	12.05	0	0
2025	11	7	18	40	0	27	0	0	0	0	0	0	0	12.03	0	0
2025	11	7	18	50	0	28	0	0	0	0	0	0	0	12.02	0	0
2025	11	7	19	0	0	26	0	0	0	0	0	0	0	12	0	0
2025	11	7	19	10	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	7	19	20	0	27	0	0	0	0	0	0	0	11.94	0	0
2025	11	7	19	30	0	27	0	0	0	0	0	0	0	11.91	0	0
2025	11	7	19	40	0	27	0	0	0	0	0	0	0	11.88	0	0
2025	11	7	19	50	0	26	0	0	0	0	0	0	0	11.84	0	0
2025	11	7	20	0	0	27	0	0	0	0	0	0	0	11.81	0	0
2025	11	7	20	10	0	27	0	0	0	0	0	0	0	11.78	0	0
2025	11	7	20	20	0	26	0	0	0	0	0	0	0	11.74	0	0
2025	11	7	20	30	0	27	0	0	0	0	0	0	0	11.7	0	0
2025	11	7	20	40	0	27	0	0	0	0	0	0	0	11.67	0	0
2025	11	7	20	50	0	27	0	0	0	0	0	0	0	11.64	0	0
2025	11	7	21	0	0	27	0	0	0	0	0	0	0	11.6	0	0
2025	11	7	21	10	0	27	0	0	0	0	0	0	0	11.57	0	0
2025	11	7	21	20	0	27	0	0	0	0	0	0	0	11.53	0	0
2025	11	7	21	30	0	27	0	0	0	0	0	0	0	11.5	0	0
2025	11	7	21	40	0	27	0	0	0	0	0	0	0	11.47	0	0
2025	11	7	21	50	0	27	0	0	0	0	0	0	0	11.44	0	0
2025	11	7	22	0	0	27	0	0	0	0	0	0	0	11.4	0	0
2025	11	7	22	10	0	28	0	0	0	0	0	0	0	11.37	0	0
2025	11	7	22	20	0	27	0	0	0	0	0	0	0	11.33	0	0
2025	11	7	22	30	0	27	0	0	0	0	0	0	0	11.3	0	0
2025	11	7	22	40	0	27	0	0	0	0	0	0	0	11.27	0	0
2025	11	7	22	50	0	27	0	0	0	0	0	0	0	11.23	0	0
2025	11	7	23	0	0	27	0	0	0	0	0	0	0	11.2	0	0
2025	11	7	23	10	0	27	0	0	0	0	0	0	0	11.16	0	0
2025	11	7	23	20	0	27	0	0	0	0	0	0	0	11.13	0	0
2025	11	7	23	30	0	27	0	0	0	0	0	0	0	11.1	0	0
2025	11	7	23	40	0	27	0	0	0	0	0	0	0	11.07	0	0
2025	11	7	23	50	0	27	0	0	0	0	0	0	0	11.03	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	8	0	0	0	27	0	0	0	0	0	0	0	11	0	0
2025	11	8	0	10	0	27	0	0	0	0	0	0	0	10.97	0	0
2025	11	8	0	20	0	27	0	0	0	0	0	0	0	10.94	0	0
2025	11	8	0	30	0	27	0	0	0	0	0	0	0	10.91	0	0
2025	11	8	0	40	0	28	0	0	0	0	0	0	0	10.88	0	0
2025	11	8	0	50	0	27	0	0	0	0	0	0	0	10.85	0	0
2025	11	8	1	0	0	27	0	0	0	0	0	0	0	10.82	0	0
2025	11	8	1	10	0	27	0	0	0	0	0	0	0	10.79	0	0
2025	11	8	1	20	0	27	0	0	0	0	0	0	0	10.76	0	0
2025	11	8	1	30	0	27	0	0	0	0	0	0	0	10.73	0	0
2025	11	8	1	40	0	27	0	0	0	0	0	0	0	10.7	0	0
2025	11	8	1	50	0	27	0	0	0	0	0	0	0	10.67	0	0
2025	11	8	2	0	0	27	0	0	0	0	0	0	0	10.66	0	0
2025	11	8	2	10	0	27	0	0	0	0	0	0	0	10.63	0	0
2025	11	8	2	20	0	27	0	0	0	0	0	0	0	10.6	0	0
2025	11	8	2	30	0	27	0	0	0	0	0	0	0	10.58	0	0
2025	11	8	2	40	0	27	0	0	0	0	0	0	0	10.56	0	0
2025	11	8	2	50	0	28	0	0	0	0	0	0	0	10.54	0	0
2025	11	8	3	0	0	27	0	0	0	0	0	0	0	10.52	0	0
2025	11	8	3	10	0	28	0	0	0	0	0	0	0	10.5	0	0
2025	11	8	3	20	0	28	0	0	0	0	0	0	0	10.48	0	0
2025	11	8	3	30	0	27	0	0	0	0	0	0	0	10.46	0	0
2025	11	8	3	40	0	27	0	0	0	0	0	0	0	10.45	0	0
2025	11	8	3	50	0	27	0	0	0	0	0	0	0	10.44	0	0
2025	11	8	4	0	0	27	0	0	0	0	0	0	0	10.42	0	0
2025	11	8	4	10	0	27	0	0	0	0	0	0	0	10.41	0	0
2025	11	8	4	20	0	27	0	0	0	0	0	0	0	10.4	0	0
2025	11	8	4	30	0	27	0	0	0	0	0	0	0	10.39	0	0
2025	11	8	4	40	0	28	0	0	0	0	0	0	0	10.37	0	0
2025	11	8	4	50	0	28	0	0	0	0	0	0	0	10.36	0	0
2025	11	8	5	0	0	27	0	0	0	0	0	0	0	10.35	0	0
2025	11	8	5	10	0	28	0	0	0	0	0	0	0	10.34	0	0
2025	11	8	5	20	0	27	0	0	0	0	0	0	0	10.33	0	0
2025	11	8	5	30	0	26	0	0	0	0	0	0	0	10.32	0	0
2025	11	8	5	40	0	27	0	0	0	0	0	0	0	10.31	0	0
2025	11	8	5	50	0	28	0	0	0	0	0	0	0	10.3	0	0
2025	11	8	6	0	0	27	0	0	0	0	0	0	0	10.29	0	0
2025	11	8	6	10	0	28	0	0	0	0	0	0	0	10.29	0	0
2025	11	8	6	20	0	28	0	0	0	0	0	0	0	10.27	0	0
2025	11	8	6	30	0	27	0	0	0	0	0	0	0	10.27	0	0
2025	11	8	6	40	0	27	0	0	0	0	0	0	0	10.26	0	0
2025	11	8	6	50	0	28	0	0	0	0	0	0	0	10.25	0	0
2025	11	8	7	0	0	28	0	0	0	0	0	0	0	10.24	0	0
2025	11	8	7	10	0	27	0	0	0	0	0	0	0	10.23	0	0
2025	11	8	7	20	0	27	0	0	0	0	0	0	0	10.21	0	0
2025	11	8	7	30	0	27	0	0	0	0	0	0	0	10.2	0	0
2025	11	8	7	40	0	27	0	0	0	0	0	0	0	10.2	0	0
2025	11	8	7	50	0	27	0	0	0	0	0	0	0	10.18	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	8	8	0	0	27	0	0	0	0	0	0	0	10.18	0	0
2025	11	8	8	10	0	27	0	0	0	0	0	0	0	10.17	0	0
2025	11	8	8	20	0	28	0	0	0	0	0	0	0	10.17	0	0
2025	11	8	8	30	0	28	0	0	0	0	0	0	0	10.16	0	0
2025	11	8	8	40	0	27	0	0	0	0	0	0	0	10.16	0	0
2025	11	8	8	50	0	27	0	0	0	0	0	0	0	10.16	0	0
2025	11	8	9	0	0	28	0	0	0	0	0	0	0	10.17	0	0
2025	11	8	9	10	0	27	0	0	0	0	0	0	0	10.18	0	0
2025	11	8	9	20	0	28	0	0	0	0	0	0	0	10.2	0	0
2025	11	8	9	30	0	28	0	0	0	0	0	0	0	10.21	0	0
2025	11	8	9	40	0	28	0	0	0	0	0	0	0	10.24	0	0
2025	11	8	9	50	0	27	0	0	0	0	0	0	0	10.27	0	0
2025	11	8	10	0	0	27	0	0	0	0	0	0	0	10.29	0	0
2025	11	8	10	10	0	27	0	0	0	0	0	0	0	10.34	0	0
2025	11	8	10	20	0	27	0	0	0	0	0	0	0	10.37	0	0
2025	11	8	10	30	0	27	0	0	0	0	0	0	0	10.41	0	0
2025	11	8	10	40	0	28	0	0	0	0	0	0	0	10.46	0	0
2025	11	8	10	50	0	27	0	0	0	0	0	0	0	10.51	0	0
2025	11	8	11	0	0	27	0	0	0	0	0	0	0	10.55	0	0
2025	11	8	11	10	0	28	0	0	0	0	0	0	0	10.61	0	0
2025	11	8	11	20	0	27	0	0	0	0	0	0	0	10.66	0	0
2025	11	8	11	30	0	27	0	0	0	0	0	0	0	10.72	0	0
2025	11	8	11	40	0	27	0	0	0	0	0	0	0	10.78	0	0
2025	11	8	11	50	0	27	0	0	0	0	0	0	0	10.84	0	0
2025	11	8	12	0	0	28	0	0	0	0	0	0	0	10.9	0	0
2025	11	8	12	10	0	27	0	0	0	0	0	0	0	10.96	0	0
2025	11	8	12	20	0	27	0	0	0	0	0	0	0	11.02	0	0
2025	11	8	12	30	0	28	0	0	0	0	0	0	0	11.08	0	0
2025	11	8	12	40	0	27	0	0	0	0	0	0	0	11.14	0	0
2025	11	8	12	50	0	27	0	0	0	0	0	0	0	11.2	0	0
2025	11	8	13	0	0	27	0	0	0	0	0	0	0	11.26	0	0
2025	11	8	13	10	0	27	0	0	0	0	0	0	0	11.32	0	0
2025	11	8	13	20	0	27	0	0	0	0	0	0	0	11.38	0	0
2025	11	8	13	30	0	27	0	0	0	0	0	0	0	11.44	0	0
2025	11	8	13	40	0	27	0	0	0	0	0	0	0	11.5	0	0
2025	11	8	13	50	0	27	0	0	0	0	0	0	0	11.56	0	0
2025	11	8	14	0	0	27	0	0	0	0	0	0	0	11.62	0	0
2025	11	8	14	10	0	27	0	0	0	0	0	0	0	11.67	0	0
2025	11	8	14	20	0	27	0	0	0	0	0	0	0	11.72	0	0
2025	11	8	14	30	0	26	0	0	0	0	0	0	0	11.78	0	0
2025	11	8	14	40	0	27	0	0	0	0	0	0	0	11.82	0	0
2025	11	8	14	50	0	27	0	0	0	0	0	0	0	11.88	0	0
2025	11	8	15	0	0	27	0	0	0	0	0	0	0	11.92	0	0
2025	11	8	15	10	0	27	0	0	0	0	0	0	0	11.96	0	0
2025	11	8	15	20	0	27	0	0	0	0	0	0	0	12	0	0
2025	11	8	15	30	0	27	0	0	0	0	0	0	0	12.04	0	0
2025	11	8	15	40	0	27	0	0	0	0	0	0	0	12.07	0	0
2025	11	8	15	50	0	27	0	0	0	0	0	0	0	12.11	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	8	16	0	0	27	0	0	0	0	0	0	0	12.13	0	0
2025	11	8	16	10	0	27	0	0	0	0	0	0	0	12.16	0	0
2025	11	8	16	20	0	27	0	0	0	0	0	0	0	12.18	0	0
2025	11	8	16	30	0	28	0	0	0	0	0	0	0	12.2	0	0
2025	11	8	16	40	0	27	0	0	0	0	0	0	0	12.22	0	0
2025	11	8	16	50	0	27	0	0	0	0	0	0	0	12.24	0	0
2025	11	8	17	0	0	27	0	0	0	0	0	0	0	12.26	0	0
2025	11	8	17	10	0	27	0	0	0	0	0	0	0	12.28	0	0
2025	11	8	17	20	0	27	0	0	0	0	0	0	0	12.29	0	0
2025	11	8	17	30	0	26	0	0	0	0	0	0	0	12.29	0	0
2025	11	8	17	40	0	26	0	0	0	0	0	0	0	12.3	0	0
2025	11	8	17	50	0	26	0	0	0	0	0	0	0	12.3	0	0
2025	11	8	18	0	0	26	0	0	0	0	0	0	0	12.3	0	0
2025	11	8	18	10	0	27	0	0	0	0	0	0	0	12.29	0	0
2025	11	8	18	20	0	27	0	0	0	0	0	0	0	12.29	0	0
2025	11	8	18	30	0	27	0	0	0	0	0	0	0	12.27	0	0
2025	11	8	18	40	0	27	0	0	0	0	0	0	0	12.26	0	0
2025	11	8	18	50	0	27	0	0	0	0	0	0	0	12.25	0	0
2025	11	8	19	0	0	27	0	0	0	0	0	0	0	12.23	0	0
2025	11	8	19	10	0	28	0	0	0	0	0	0	0	12.21	0	0
2025	11	8	19	20	0	27	0	0	0	0	0	0	0	12.19	0	0
2025	11	8	19	30	0	26	0	0	0	0	0	0	0	12.17	0	0
2025	11	8	19	40	0	27	0	0	0	0	0	0	0	12.14	0	0
2025	11	8	19	50	0	27	0	0	0	0	0	0	0	12.11	0	0
2025	11	8	20	0	0	27	0	0	0	0	0	0	0	12.08	0	0
2025	11	8	20	10	0	27	0	0	0	0	0	0	0	12.05	0	0
2025	11	8	20	20	0	27	0	0	0	0	0	0	0	12.02	0	0
2025	11	8	20	30	0	27	0	0	0	0	0	0	0	11.99	0	0
2025	11	8	20	40	0	26	0	0	0	0	0	0	0	11.96	0	0
2025	11	8	20	50	0	27	0	0	0	0	0	0	0	11.93	0	0
2025	11	8	21	0	0	27	0	0	0	0	0	0	0	11.9	0	0
2025	11	8	21	10	0	27	0	0	0	0	0	0	0	11.87	0	0
2025	11	8	21	20	0	27	0	0	0	0	0	0	0	11.84	0	0
2025	11	8	21	30	0	27	0	0	0	0	0	0	0	11.81	0	0
2025	11	8	21	40	0	26	0	0	0	0	0	0	0	11.78	0	0
2025	11	8	21	50	0	26	0	0	0	0	0	0	0	11.74	0	0
2025	11	8	22	0	0	27	0	0	0	0	0	0	0	11.72	0	0
2025	11	8	22	10	0	27	0	0	0	0	0	0	0	11.69	0	0
2025	11	8	22	20	0	27	0	0	0	0	0	0	0	11.65	0	0
2025	11	8	22	30	0	27	0	0	0	0	0	0	0	11.62	0	0
2025	11	8	22	40	0	27	0	0	0	0	0	0	0	11.59	0	0
2025	11	8	22	50	0	27	0	0	0	0	0	0	0	11.56	0	0
2025	11	8	23	0	0	27	0	0	0	0	0	0	0	11.53	0	0
2025	11	8	23	10	0	27	0	0	0	0	0	0	0	11.51	0	0
2025	11	8	23	20	0	27	0	0	0	0	0	0	0	11.47	0	0
2025	11	8	23	30	0	28	0	0	0	0	0	0	0	11.44	0	0
2025	11	8	23	40	0	27	0	0	0	0	0	0	0	11.41	0	0
2025	11	8	23	50	0	27	0	0	0	0	0	0	0	11.38	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	9	0	0	0	27	0	0	0	0	0	0	0	11.36	0	0
2025	11	9	0	10	0	27	0	0	0	0	0	0	0	11.32	0	0
2025	11	9	0	20	0	27	0	0	0	0	0	0	0	11.29	0	0
2025	11	9	0	30	0	28	0	0	0	0	0	0	0	11.27	0	0
2025	11	9	0	40	0	27	0	0	0	0	0	0	0	11.23	0	0
2025	11	9	0	50	0	27	0	0	0	0	0	0	0	11.2	0	0
2025	11	9	1	0	0	26	0	0	0	0	0	0	0	11.17	0	0
2025	11	9	1	10	0	27	0	0	0	0	0	0	0	11.15	0	0
2025	11	9	1	20	0	27	0	0	0	0	0	0	0	11.12	0	0
2025	11	9	1	30	0	27	0	0	0	0	0	0	0	11.09	0	0
2025	11	9	1	40	0	27	0	0	0	0	0	0	0	11.07	0	0
2025	11	9	1	50	0	27	0	0	0	0	0	0	0	11.04	0	0
2025	11	9	2	0	0	28	0	0	0	0	0	0	0	11.01	0	0
2025	11	9	2	10	0	27	0	0	0	0	0	0	0	10.98	0	0
2025	11	9	2	20	0	27	0	0	0	0	0	0	0	10.96	0	0
2025	11	9	2	30	0	27	0	0	0	0	0	0	0	10.93	0	0
2025	11	9	2	40	0	28	0	0	0	0	0	0	0	10.91	0	0
2025	11	9	2	50	0	27	0	0	0	0	0	0	0	10.89	0	0
2025	11	9	3	0	0	27	0	0	0	0	0	0	0	10.87	0	0
2025	11	9	3	10	0	28	0	0	0	0	0	0	0	10.85	0	0
2025	11	9	3	20	0	27	0	0	0	0	0	0	0	10.82	0	0
2025	11	9	3	30	0	28	0	0	0	0	0	0	0	10.8	0	0
2025	11	9	3	40	0	27	0	0	0	0	0	0	0	10.79	0	0
2025	11	9	3	50	0	28	0	0	0	0	0	0	0	10.77	0	0
2025	11	9	4	0	0	28	0	0	0	0	0	0	0	10.75	0	0
2025	11	9	4	10	0	27	0	0	0	0	0	0	0	10.74	0	0
2025	11	9	4	20	0	27	0	0	0	0	0	0	0	10.73	0	0
2025	11	9	4	30	0	27	0	0	0	0	0	0	0	10.71	0	0
2025	11	9	4	40	0	27	0	0	0	0	0	0	0	10.69	0	0
2025	11	9	4	50	0	27	0	0	0	0	0	0	0	10.67	0	0
2025	11	9	5	0	0	27	0	0	0	0	0	0	0	10.67	0	0
2025	11	9	5	10	0	27	0	0	0	0	0	0	0	10.65	0	0
2025	11	9	5	20	0	27	0	0	0	0	0	0	0	10.64	0	0
2025	11	9	5	30	0	27	0	0	0	0	0	0	0	10.62	0	0
2025	11	9	5	40	0	27	0	0	0	0	0	0	0	10.6	0	0
2025	11	9	5	50	0	26	0	0	0	0	0	0	0	10.6	0	0
2025	11	9	6	0	0	27	0	0	0	0	0	0	0	10.58	0	0
2025	11	9	6	10	0	27	0	0	0	0	0	0	0	10.57	0	0
2025	11	9	6	20	0	27	0	0	0	0	0	0	0	10.56	0	0
2025	11	9	6	30	0	27	0	0	0	0	0	0	0	10.54	0	0
2025	11	9	6	40	0	27	0	0	0	0	0	0	0	10.53	0	0
2025	11	9	6	50	0	27	0	0	0	0	0	0	0	10.52	0	0
2025	11	9	7	0	0	27	0	0	0	0	0	0	0	10.51	0	0
2025	11	9	7	10	0	28	0	0	0	0	0	0	0	10.5	0	0
2025	11	9	7	20	0	28	0	0	0	0	0	0	0	10.48	0	0
2025	11	9	7	30	0	27	0	0	0	0	0	0	0	10.47	0	0
2025	11	9	7	40	0	27	0	0	0	0	0	0	0	10.45	0	0
2025	11	9	7	50	0	27	0	0	0	0	0	0	0	10.44	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	9	8	0	0	27	0	0	0	0	0	0	0	10.43	0	0
2025	11	9	8	10	0	28	0	0	0	0	0	0	0	10.42	0	0
2025	11	9	8	20	0	27	0	0	0	0	0	0	0	10.41	0	0
2025	11	9	8	30	0	28	0	0	0	0	0	0	0	10.4	0	0
2025	11	9	8	40	0	28	0	0	0	0	0	0	0	10.39	0	0
2025	11	9	8	50	0	27	0	0	0	0	0	0	0	10.39	0	0
2025	11	9	9	0	0	27	0	0	0	0	0	0	0	10.39	0	0
2025	11	9	9	10	0	27	0	0	0	0	0	0	0	10.4	0	0
2025	11	9	9	20	0	27	0	0	0	0	0	0	0	10.42	0	0
2025	11	9	9	30	0	27	0	0	0	0	0	0	0	10.43	0	0
2025	11	9	9	40	0	28	0	0	0	0	0	0	0	10.45	0	0
2025	11	9	9	50	0	28	0	0	0	0	0	0	0	10.47	0	0
2025	11	9	10	0	0	27	0	0	0	0	0	0	0	10.5	0	0
2025	11	9	10	10	0	27	0	0	0	0	0	0	0	10.53	0	0
2025	11	9	10	20	0	27	0	0	0	0	0	0	0	10.56	0	0
2025	11	9	10	30	0	27	0	0	0	0	0	0	0	10.6	0	0
2025	11	9	10	40	0	27	0	0	0	0	0	0	0	10.64	0	0
2025	11	9	10	50	0	27	0	0	0	0	0	0	0	10.68	0	0
2025	11	9	11	0	0	27	0	0	0	0	0	0	0	10.72	0	0
2025	11	9	11	10	0	27	0	0	0	0	0	0	0	10.77	0	0
2025	11	9	11	20	0	27	0	0	0	0	0	0	0	10.82	0	0
2025	11	9	11	30	0	27	0	0	0	0	0	0	0	10.87	0	0
2025	11	9	11	40	0	27	0	0	0	0	0	0	0	10.92	0	0
2025	11	9	11	50	0	27	0	0	0	0	0	0	0	10.98	0	0
2025	11	9	12	0	0	27	0	0	0	0	0	0	0	11.03	0	0
2025	11	9	12	10	0	28	0	0	0	0	0	0	0	11.09	0	0
2025	11	9	12	20	0	27	0	0	0	0	0	0	0	11.14	0	0
2025	11	9	12	30	0	27	0	0	0	0	0	0	0	11.2	0	0
2025	11	9	12	40	0	27	0	0	0	0	0	0	0	11.26	0	0
2025	11	9	12	50	0	27	0	0	0	0	0	0	0	11.31	0	0
2025	11	9	13	0	0	27	0	0	0	0	0	0	0	11.37	0	0
2025	11	9	13	10	0	27	0	0	0	0	0	0	0	11.43	0	0
2025	11	9	13	20	0	28	0	0	0	0	0	0	0	11.48	0	0
2025	11	9	13	30	0	27	0	0	0	0	0	0	0	11.54	0	0
2025	11	9	13	40	0	27	0	0	0	0	0	0	0	11.59	0	0
2025	11	9	13	50	0	27	0	0	0	0	0	0	0	11.65	0	0
2025	11	9	14	0	0	26	0	0	0	0	0	0	0	11.7	0	0
2025	11	9	14	10	0	27	0	0	0	0	0	0	0	11.75	0	0
2025	11	9	14	20	0	27	0	0	0	0	0	0	0	11.8	0	0
2025	11	9	14	30	0	27	0	0	0	0	0	0	0	11.84	0	0
2025	11	9	14	40	0	27	0	0	0	0	0	0	0	11.88	0	0
2025	11	9	14	50	0	27	0	0	0	0	0	0	0	11.93	0	0
2025	11	9	15	0	0	26	0	0	0	0	0	0	0	11.97	0	0
2025	11	9	15	10	0	28	0	0	0	0	0	0	0	12	0	0
2025	11	9	15	20	0	27	0	0	0	0	0	0	0	12.04	0	0
2025	11	9	15	30	0	27	0	0	0	0	0	0	0	12.07	0	0
2025	11	9	15	40	0	27	0	0	0	0	0	0	0	12.1	0	0
2025	11	9	15	50	0	27	0	0	0	0	0	0	0	12.13	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

[illegible]

Mazourka (0354)

[illegible]

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	11	10	16	0	0	27	0	0	0	0	0	0	0	11.74	0	0
	2025	11	10	16	10	0	27	0	0	0	0	0	0	0	11.76	0	0
	2025	11	10	16	20	0	27	0	0	0	0	0	0	0	11.78	0	0
	2025	11	10	16	30	0	27	0	0	0	0	0	0	0	11.8	0	0
	2025	11	10	16	40	0	27	0	0	0	0	0	0	0	11.82	0	0
	2025	11	10	16	50	0	27	0	0	0	0	0	0	0	11.84	0	0
	2025	11	10	17	0	0	27	0	0	0	0	0	0	0	11.85	0	0
	2025	11	10	17	10	0	27	0	0	0	0	0	0	0	11.87	0	0
	2025	11	10	17	20	0	27	0	0	0	0	0	0	0	11.87	0	0
	2025	11	10	17	30	0	27	0	0	0	0	0	0	0	11.88	0	0
	2025	11	10	17	40	0	27	0	0	0	0	0	0	0	11.88	0	0
	2025	11	10	17	50	0	27	0	0	0	0	0	0	0	11.88	0	0
	2025	11	10	18	0	0	27	0	0	0	0	0	0	0	11.88	0	0
	2025	11	10	18	10	0	27	0	0	0	0	0	0	0	11.87	0	0
	2025	11	10	18	20	0	27	0	0	0	0	0	0	0	11.86	0	0
	2025	11	10	18	30	0	26	0	0	0	0	0	0	0	11.85	0	0
	2025	11	10	18	40	0	27	0	0	0	0	0	0	0	11.83	0	0
	2025	11	10	18	50	0	27	0	0	0	0	0	0	0	11.82	0	0
	2025	11	10	19	0	0	27	0	0	0	0	0	0	0	11.79	0	0
	2025	11	10	19	10	0	27	0	0	0	0	0	0	0	11.77	0	0
	2025	11	10	19	20	0	28	0	0	0	0	0	0	0	11.75	0	0
	2025	11	10	19	30	0	27	0	0	0	0	0	0	0	11.71	0	0
	2025	11	10	19	40	0	27	0	0	0	0	0	0	0	11.68	0	0
	2025	11	10	19	50	0	27	0	0	0	0	0	0	0	11.65	0	0
	2025	11	10	20	0	0	27	0	0	0	0	0	0	0	11.62	0	0
	2025	11	10	20	10	0	27	0	0	0	0	0	0	0	11.59	0	0
	2025	11	10	20	20	0	27	0	0	0	0	0	0	0	11.56	0	0
	2025	11	10	20	30	0	27	0	0	0	0	0	0	0	11.53	0	0
	2025	11	10	20	40	0	27	0	0	0	0	0	0	0	11.49	0	0
	2025	11	10	20	50	0	27	0	0	0	0	0	0	0	11.46	0	0
	2025	11	10	21	0	0	27	0	0	0	0	0	0	0	11.43	0	0
	2025	11	10	21	10	0	27	0	0	0	0	0	0	0	11.39	0	0
	2025	11	10	21	20	0	27	0	0	0	0	0	0	0	11.36	0	0
	2025	11	10	21	30	0	27	0	0	0	0	0	0	0	11.33	0	0
	2025	11	10	21	40	0	28	0	0	0	0	0	0	0	11.3	0	0
	2025	11	10	21	50	0	28	0	0	0	0	0	0	0	11.27	0	0
	2025	11	10	22	0	0	27	0	0	0	0	0	0	0	11.24	0	0
	2025	11	10	22	10	0	27	0	0	0	0	0	0	0	11.21	0	0
	2025	11	10	22	20	0	27	0	0	0	0	0	0	0	11.18	0	0
	2025	11	10	22	30	0	27	0	0	0	0	0	0	0	11.14	0	0
	2025	11	10	22	40	0	27	0	0	0	0	0	0	0	11.11	0	0
	2025	11	10	22	50	0	27	0	0	0	0	0	0	0	11.08	0	0
	2025	11	10	23	0	0	27	0	0	0	0	0	0	0	11.05	0	0
	2025	11	10	23	10	0	27	0	0	0	0	0	0	0	11.01	0	0
	2025	11	10	23	20	0	27	0	0	0	0	0	0	0	10.98	0	0
	2025	11	10	23	30	0	27	0	0	0	0	0	0	0	10.95	0	0
	2025	11	10	23	40	0	27	0	0	0	0	0	0	0	10.92	0	0
	2025	11	10	23	50	0	27	0	0	0	0	0	0	0	10.89	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	11	0	0	0	27	0	0	0	0	0	0	0	10.86	0	0
2025	11	11	0	10	0	27	0	0	0	0	0	0	0	10.83	0	0
2025	11	11	0	20	0	27	0	0	0	0	0	0	0	10.8	0	0
2025	11	11	0	30	0	27	0	0	0	0	0	0	0	10.77	0	0
2025	11	11	0	40	0	27	0	0	0	0	0	0	0	10.74	0	0
2025	11	11	0	50	0	27	0	0	0	0	0	0	0	10.71	0	0
2025	11	11	1	0	0	27	0	0	0	0	0	0	0	10.69	0	0
2025	11	11	1	10	0	27	0	0	0	0	0	0	0	10.66	0	0
2025	11	11	1	20	0	28	0	0	0	0	0	0	0	10.63	0	0
2025	11	11	1	30	0	27	0	0	0	0	0	0	0	10.6	0	0
2025	11	11	1	40	0	27	0	0	0	0	0	0	0	10.57	0	0
2025	11	11	1	50	0	27	0	0	0	0	0	0	0	10.55	0	0
2025	11	11	2	0	0	27	0	0	0	0	0	0	0	10.52	0	0
2025	11	11	2	10	0	27	0	0	0	0	0	0	0	10.49	0	0
2025	11	11	2	20	0	26	0	0	0	0	0	0	0	10.47	0	0
2025	11	11	2	30	0	27	0	0	0	0	0	0	0	10.44	0	0
2025	11	11	2	40	0	27	0	0	0	0	0	0	0	10.41	0	0
2025	11	11	2	50	0	28	0	0	0	0	0	0	0	10.39	0	0
2025	11	11	3	0	0	27	0	0	0	0	0	0	0	10.37	0	0
2025	11	11	3	10	0	27	0	0	0	0	0	0	0	10.34	0	0
2025	11	11	3	20	0	28	0	0	0	0	0	0	0	10.32	0	0
2025	11	11	3	30	0	27	0	0	0	0	0	0	0	10.3	0	0
2025	11	11	3	40	0	28	0	0	0	0	0	0	0	10.28	0	0
2025	11	11	3	50	0	27	0	0	0	0	0	0	0	10.26	0	0
2025	11	11	4	0	0	27	0	0	0	0	0	0	0	10.24	0	0
2025	11	11	4	10	0	27	0	0	0	0	0	0	0	10.22	0	0
2025	11	11	4	20	0	27	0	0	0	0	0	0	0	10.2	0	0
2025	11	11	4	30	0	27	0	0	0	0	0	0	0	10.18	0	0
2025	11	11	4	40	0	27	0	0	0	0	0	0	0	10.17	0	0
2025	11	11	4	50	0	27	0	0	0	0	0	0	0	10.15	0	0
2025	11	11	5	0	0	27	0	0	0	0	0	0	0	10.13	0	0
2025	11	11	5	10	0	27	0	0	0	0	0	0	0	10.11	0	0
2025	11	11	5	20	0	27	0	0	0	0	0	0	0	10.1	0	0
2025	11	11	5	30	0	27	0	0	0	0	0	0	0	10.09	0	0
2025	11	11	5	40	0	28	0	0	0	0	0	0	0	10.07	0	0
2025	11	11	5	50	0	27	0	0	0	0	0	0	0	10.05	0	0
2025	11	11	6	0	0	27	0	0	0	0	0	0	0	10.03	0	0
2025	11	11	6	10	0	28	0	0	0	0	0	0	0	10.01	0	0
2025	11	11	6	20	0	28	0	0	0	0	0	0	0	10	0	0
2025	11	11	6	30	0	28	0	0	0	0	0	0	0	9.98	0	0
2025	11	11	6	40	0	27	0	0	0	0	0	0	0	9.97	0	0
2025	11	11	6	50	0	27	0	0	0	0	0	0	0	9.95	0	0
2025	11	11	7	0	0	27	0	0	0	0	0	0	0	9.93	0	0
2025	11	11	7	10	0	27	0	0	0	0	0	0	0	9.92	0	0
2025	11	11	7	20	0	27	0	0	0	0	0	0	0	9.9	0	0
2025	11	11	7	30	0	28	0	0	0	0	0	0	0	9.88	0	0
2025	11	11	7	40	0	27	0	0	0	0	0	0	0	9.86	0	0
2025	11	11	7	50	0	28	0	0	0	0	0	0	0	9.85	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	11	16	0	0	27	0	0	0	0	0	0	0	11.16	0	0
2025	11	11	16	10	0	26	0	0	0	0	0	0	0	11.18	0	0
2025	11	11	16	20	0	27	0	0	0	0	0	0	0	11.19	0	0
2025	11	11	16	30	0	27	0	0	0	0	0	0	0	11.2	0	0
2025	11	11	16	40	0	27	0	0	0	0	0	0	0	11.21	0	0
2025	11	11	16	50	0	27	0	0	0	0	0	0	0	11.22	0	0
2025	11	11	17	0	0	27	0	0	0	0	0	0	0	11.23	0	0
2025	11	11	17	10	0	27	0	0	0	0	0	0	0	11.23	0	0
2025	11	11	17	20	0	27	0	0	0	0	0	0	0	11.23	0	0
2025	11	11	17	30	0	28	0	0	0	0	0	0	0	11.22	0	0
2025	11	11	17	40	0	27	0	0	0	0	0	0	0	11.22	0	0
2025	11	11	17	50	0	27	0	0	0	0	0	0	0	11.22	0	0
2025	11	11	18	0	0	27	0	0	0	0	0	0	0	11.21	0	0
2025	11	11	18	10	0	27	0	0	0	0	0	0	0	11.2	0	0
2025	11	11	18	20	0	27	0	0	0	0	0	0	0	11.2	0	0
2025	11	11	18	30	0	27	0	0	0	0	0	0	0	11.19	0	0
2025	11	11	18	40	0	27	0	0	0	0	0	0	0	11.18	0	0
2025	11	11	18	50	0	26	0	0	0	0	0	0	0	11.18	0	0
2025	11	11	19	0	0	27	0	0	0	0	0	0	0	11.16	0	0
2025	11	11	19	10	0	27	0	0	0	0	0	0	0	11.15	0	0
2025	11	11	19	20	0	27	0	0	0	0	0	0	0	11.14	0	0
2025	11	11	19	30	0	27	0	0	0	0	0	0	0	11.12	0	0
2025	11	11	19	40	0	27	0	0	0	0	0	0	0	11.11	0	0
2025	11	11	19	50	0	27	0	0	0	0	0	0	0	11.1	0	0
2025	11	11	20	0	0	28	0	0	0	0	0	0	0	11.09	0	0
2025	11	11	20	10	0	27	0	0	0	0	0	0	0	11.07	0	0
2025	11	11	20	20	0	26	0	0	0	0	0	0	0	11.06	0	0
2025	11	11	20	30	0	27	0	0	0	0	0	0	0	11.05	0	0
2025	11	11	20	40	0	27	0	0	0	0	0	0	0	11.04	0	0
2025	11	11	20	50	0	27	0	0	0	0	0	0	0	11.03	0	0
2025	11	11	21	0	0	27	0	0	0	0	0	0	0	11.02	0	0
2025	11	11	21	10	0	27	0	0	0	0	0	0	0	11.01	0	0
2025	11	11	21	20	0	27	0	0	0	0	0	0	0	11	0	0
2025	11	11	21	30	0	27	0	0	0	0	0	0	0	10.98	0	0
2025	11	11	21	40	0	27	0	0	0	0	0	0	0	10.97	0	0
2025	11	11	21	50	0	27	0	0	0	0	0	0	0	10.96	0	0
2025	11	11	22	0	0	28	0	0	0	0	0	0	0	10.94	0	0
2025	11	11	22	10	0	28	0	0	0	0	0	0	0	10.93	0	0
2025	11	11	22	20	0	27	0	0	0	0	0	0	0	10.92	0	0
2025	11	11	22	30	0	27	0	0	0	0	0	0	0	10.91	0	0
2025	11	11	22	40	0	27	0	0	0	0	0	0	0	10.9	0	0
2025	11	11	22	50	0	27	0	0	0	0	0	0	0	10.88	0	0
2025	11	11	23	0	0	27	0	0	0	0	0	0	0	10.86	0	0
2025	11	11	23	10	0	27	0	0	0	0	0	0	0	10.85	0	0
2025	11	11	23	20	0	27	0	0	0	0	0	0	0	10.83	0	0
2025	11	11	23	30	0	27	0	0	0	0	0	0	0	10.81	0	0
2025	11	11	23	40	0	27	0	0	0	0	0	0	0	10.8	0	0
2025	11	11	23	50	0	27	0	0	0	0	0	0	0	10.78	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	12	8	0	0	28	0	0	0	0	0	0	0	10.55	0	0
2025	11	12	8	10	0	27	0	0	0	0	0	0	0	10.55	0	0
2025	11	12	8	20	0	28	0	0	0	0	0	0	0	10.55	0	0
2025	11	12	8	30	0	27	0	0	0	0	0	0	0	10.56	0	0
2025	11	12	8	40	0	27	0	0	0	0	0	0	0	10.56	0	0
2025	11	12	8	50	0	27	0	0	0	0	0	0	0	10.57	0	0
2025	11	12	9	0	0	27	0	0	0	0	0	0	0	10.57	0	0
2025	11	12	9	10	0	27	0	0	0	0	0	0	0	10.58	0	0
2025	11	12	9	20	0	28	0	0	0	0	0	0	0	10.58	0	0
2025	11	12	9	30	0	27	0	0	0	0	0	0	0	10.6	0	0
2025	11	12	9	40	0	27	0	0	0	0	0	0	0	10.61	0	0
2025	11	12	9	50	0	27	0	0	0	0	0	0	0	10.62	0	0
2025	11	12	10	0	0	27	0	0	0	0	0	0	0	10.64	0	0
2025	11	12	10	10	0	27	0	0	0	0	0	0	0	10.65	0	0
2025	11	12	10	20	0	28	0	0	0	0	0	0	0	10.67	0	0
2025	11	12	10	30	0	28	0	0	0	0	0	0	0	10.69	0	0
2025	11	12	10	40	0	27	0	0	0	0	0	0	0	10.71	0	0
2025	11	12	10	50	0	27	0	0	0	0	0	0	0	10.73	0	0
2025	11	12	11	0	0	28	0	0	0	0	0	0	0	10.75	0	0
2025	11	12	11	10	0	27	0	0	0	0	0	0	0	10.76	0	0
2025	11	12	11	20	0	27	0	0	0	0	0	0	0	10.78	0	0
2025	11	12	11	30	0	27	0	0	0	0	0	0	0	10.79	0	0
2025	11	12	11	40	0	27	0	0	0	0	0	0	0	10.82	0	0
2025	11	12	11	50	0	27	0	0	0	0	0	0	0	10.83	0	0
2025	11	12	12	0	0	28	0	0	0	0	0	0	0	10.85	0	0
2025	11	12	12	10	0	27	0	0	0	0	0	0	0	10.87	0	0
2025	11	12	12	20	0	27	0	0	0	0	0	0	0	10.89	0	0
2025	11	12	12	30	0	28	0	0	0	0	0	0	0	10.93	0	0
2025	11	12	12	40	0	28	0	0	0	0	0	0	0	10.96	0	0
2025	11	12	12	50	0	27	0	0	0	0	0	0	0	10.98	0	0
2025	11	12	13	0	0	27	0	0	0	0	0	0	0	11.02	0	0
2025	11	12	13	10	0	27	0	0	0	0	0	0	0	11.05	0	0
2025	11	12	13	20	0	27	0	0	0	0	0	0	0	11.09	0	0
2025	11	12	13	30	0	27	0	0	0	0	0	0	0	11.13	0	0
2025	11	12	13	40	0	27	0	0	0	0	0	0	0	11.17	0	0
2025	11	12	13	50	0	28	0	0	0	0	0	0	0	11.22	0	0
2025	11	12	14	0	0	27	0	0	0	0	0	0	0	11.26	0	0
2025	11	12	14	10	0	27	0	0	0	0	0	0	0	11.3	0	0
2025	11	12	14	20	0	27	0	0	0	0	0	0	0	11.34	0	0
2025	11	12	14	30	0	27	0	0	0	0	0	0	0	11.39	0	0
2025	11	12	14	40	0	27	0	0	0	0	0	0	0	11.43	0	0
2025	11	12	14	50	0	28	0	0	0	0	0	0	0	11.46	0	0
2025	11	12	15	0	0	28	0	0	0	0	0	0	0	11.5	0	0
2025	11	12	15	10	0	27	0	0	0	0	0	0	0	11.53	0	0
2025	11	12	15	20	0	27	0	0	0	0	0	0	0	11.56	0	0
2025	11	12	15	30	0	26	0	0	0	0	0	0	0	11.58	0	0
2025	11	12	15	40	0	27	0	0	0	0	0	0	0	11.61	0	0
2025	11	12	15	50	0	27	0	0	0	0	0	0	0	11.63	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	11	12	16	0	0	27	0	0	0	0	0	0	0	11.64	0	0
	2025	11	12	16	10	0	27	0	0	0	0	0	0	0	11.65	0	0
	2025	11	12	16	20	0	27	0	0	0	0	0	0	0	11.66	0	0
	2025	11	12	16	30	0	27	0	0	0	0	0	0	0	11.67	0	0
	2025	11	12	16	40	0	27	0	0	0	0	0	0	0	11.68	0	0
	2025	11	12	16	50	0	27	0	0	0	0	0	0	0	11.68	0	0
	2025	11	12	17	0	0	27	0	0	0	0	0	0	0	11.68	0	0
	2025	11	12	17	10	0	27	0	0	0	0	0	0	0	11.69	0	0
	2025	11	12	17	20	0	27	0	0	0	0	0	0	0	11.69	0	0
	2025	11	12	17	30	0	27	0	0	0	0	0	0	0	11.68	0	0
	2025	11	12	17	40	0	27	0	0	0	0	0	0	0	11.68	0	0
	2025	11	12	17	50	0	27	0	0	0	0	0	0	0	11.68	0	0
	2025	11	12	18	0	0	27	0	0	0	0	0	0	0	11.67	0	0
	2025	11	12	18	10	0	27	0	0	0	0	0	0	0	11.67	0	0
	2025	11	12	18	20	0	27	0	0	0	0	0	0	0	11.66	0	0
	2025	11	12	18	30	0	27	0	0	0	0	0	0	0	11.65	0	0
	2025	11	12	18	40	0	27	0	0	0	0	0	0	0	11.64	0	0
	2025	11	12	18	50	0	27	0	0	0	0	0	0	0	11.63	0	0
	2025	11	12	19	0	0	27	0	0	0	0	0	0	0	11.61	0	0
	2025	11	12	19	10	0	26	0	0	0	0	0	0	0	11.6	0	0
	2025	11	12	19	20	0	27	0	0	0	0	0	0	0	11.58	0	0
	2025	11	12	19	30	0	27	0	0	0	0	0	0	0	11.56	0	0
	2025	11	12	19	40	0	27	0	0	0	0	0	0	0	11.54	0	0
	2025	11	12	19	50	0	27	0	0	0	0	0	0	0	11.52	0	0
	2025	11	12	20	0	0	27	0	0	0	0	0	0	0	11.51	0	0
	2025	11	12	20	10	0	27	0	0	0	0	0	0	0	11.49	0	0
	2025	11	12	20	20	0	27	0	0	0	0	0	0	0	11.48	0	0
	2025	11	12	20	30	0	27	0	0	0	0	0	0	0	11.46	0	0
	2025	11	12	20	40	0	27	0	0	0	0	0	0	0	11.44	0	0
	2025	11	12	20	50	0	27	0	0	0	0	0	0	0	11.42	0	0
	2025	11	12	21	0	0	27	0	0	0	0	0	0	0	11.4	0	0
	2025	11	12	21	10	0	27	0	0	0	0	0	0	0	11.39	0	0
	2025	11	12	21	20	0	27	0	0	0	0	0	0	0	11.37	0	0
	2025	11	12	21	30	0	27	0	0	0	0	0	0	0	11.35	0	0
	2025	11	12	21	40	0	27	0	0	0	0	0	0	0	11.34	0	0
	2025	11	12	21	50	0	27	0	0	0	0	0	0	0	11.32	0	0
	2025	11	12	22	0	0	27	0	0	0	0	0	0	0	11.31	0	0
	2025	11	12	22	10	0	27	0	0	0	0	0	0	0	11.29	0	0
	2025	11	12	22	20	0	27	0	0	0	0	0	0	0	11.28	0	0
	2025	11	12	22	30	0	27	0	0	0	0	0	0	0	11.26	0	0
	2025	11	12	22	40	0	27	0	0	0	0	0	0	0	11.24	0	0
	2025	11	12	22	50	0	28	0	0	0	0	0	0	0	11.23	0	0
	2025	11	12	23	0	0	28	0	0	0	0	0	0	0	11.21	0	0
	2025	11	12	23	10	0	27	0	0	0	0	0	0	0	11.19	0	0
	2025	11	12	23	20	0	27	0	0	0	0	0	0	0	11.18	0	0
	2025	11	12	23	30	0	27	0	0	0	0	0	0	0	11.16	0	0
	2025	11	12	23	40	0	27	0	0	0	0	0	0	0	11.14	0	0
	2025	11	12	23	50	0	26	0	0	0	0	0	0	0	11.13	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	13	0	0	0	28	0	0	0	0	0	0	0	11.11	0	0
2025	11	13	0	10	0	27	0	0	0	0	0	0	0	11.09	0	0
2025	11	13	0	20	0	27	0	0	0	0	0	0	0	11.07	0	0
2025	11	13	0	30	0	28	0	0	0	0	0	0	0	11.05	0	0
2025	11	13	0	40	0	27	0	0	0	0	0	0	0	11.03	0	0
2025	11	13	0	50	0	28	0	0	0	0	0	0	0	11.01	0	0
2025	11	13	1	0	0	27	0	0	0	0	0	0	0	11	0	0
2025	11	13	1	10	0	27	0	0	0	0	0	0	0	10.98	0	0
2025	11	13	1	20	0	27	0	0	0	0	0	0	0	10.96	0	0
2025	11	13	1	30	0	27	0	0	0	0	0	0	0	10.95	0	0
2025	11	13	1	40	0	28	0	0	0	0	0	0	0	10.93	0	0
2025	11	13	1	50	0	27	0	0	0	0	0	0	0	10.92	0	0
2025	11	13	2	0	0	27	0	0	0	0	0	0	0	10.9	0	0
2025	11	13	2	10	0	27	0	0	0	0	0	0	0	10.88	0	0
2025	11	13	2	20	0	28	0	0	0	0	0	0	0	10.87	0	0
2025	11	13	2	30	0	27	0	0	0	0	0	0	0	10.85	0	0
2025	11	13	2	40	0	27	0	0	0	0	0	0	0	10.83	0	0
2025	11	13	2	50	0	27	0	0	0	0	0	0	0	10.82	0	0
2025	11	13	3	0	0	27	0	0	0	0	0	0	0	10.8	0	0
2025	11	13	3	10	0	28	0	0	0	0	0	0	0	10.79	0	0
2025	11	13	3	20	0	28	0	0	0	0	0	0	0	10.77	0	0
2025	11	13	3	30	0	28	0	0	0	0	0	0	0	10.77	0	0
2025	11	13	3	40	0	28	0	0	0	0	0	0	0	10.76	0	0
2025	11	13	3	50	0	28	0	0	0	0	0	0	0	10.75	0	0
2025	11	13	4	0	0	27	0	0	0	0	0	0	0	10.74	0	0
2025	11	13	4	10	0	28	0	0	0	0	0	0	0	10.72	0	0
2025	11	13	4	20	0	28	0	0	0	0	0	0	0	10.71	0	0
2025	11	13	4	30	0	27	0	0	0	0	0	0	0	10.7	0	0
2025	11	13	4	40	0	27	0	0	0	0	0	0	0	10.69	0	0
2025	11	13	4	50	0	27	0	0	0	0	0	0	0	10.68	0	0
2025	11	13	5	0	0	27	0	0	0	0	0	0	0	10.67	0	0
2025	11	13	5	10	0	28	0	0	0	0	0	0	0	10.66	0	0
2025	11	13	5	20	0	27	0	0	0	0	0	0	0	10.66	0	0
2025	11	13	5	30	0	27	0	0	0	0	0	0	0	10.65	0	0
2025	11	13	5	40	0	28	0	0	0	0	0	0	0	10.64	0	0
2025	11	13	5	50	0	27	0	0	0	0	0	0	0	10.64	0	0
2025	11	13	6	0	0	28	0	0	0	0	0	0	0	10.63	0	0
2025	11	13	6	10	0	27	0	0	0	0	0	0	0	10.62	0	0
2025	11	13	6	20	0	28	0	0	0	0	0	0	0	10.62	0	0
2025	11	13	6	30	0	28	0	0	0	0	0	0	0	10.61	0	0
2025	11	13	6	40	0	27	0	0	0	0	0	0	0	10.61	0	0
2025	11	13	6	50	0	28	0	0	0	0	0	0	0	10.61	0	0
2025	11	13	7	0	0	27	0	0	0	0	0	0	0	10.61	0	0
2025	11	13	7	10	0	27	0	0	0	0	0	0	0	10.6	0	0
2025	11	13	7	20	0	27	0	0	0	0	0	0	0	10.6	0	0
2025	11	13	7	30	0	27	0	0	0	0	0	0	0	10.59	0	0
2025	11	13	7	40	0	27	0	0	0	0	0	0	0	10.59	0	0
2025	11	13	7	50	0	27	0	0	0	0	0	0	0	10.59	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	11	13	16	0	0	27	0	0	0	0	0	0	0	11.97	0	0
	2025	11	13	16	10	0	27	0	0	0	0	0	0	0	11.98	0	0
	2025	11	13	16	20	0	27	0	0	0	0	0	0	0	11.99	0	0
	2025	11	13	16	30	0	27	0	0	0	0	0	0	0	12.01	0	0
	2025	11	13	16	40	0	27	0	0	0	0	0	0	0	12.02	0	0
	2025	11	13	16	50	0	27	0	0	0	0	0	0	0	12.03	0	0
	2025	11	13	17	0	0	27	0	0	0	0	0	0	0	12.05	0	0
	2025	11	13	17	10	0	26	0	0	0	0	0	0	0	12.06	0	0
	2025	11	13	17	20	0	27	0	0	0	0	0	0	0	12.07	0	0
	2025	11	13	17	30	0	27	0	0	0	0	0	0	0	12.08	0	0
	2025	11	13	17	40	0	27	0	0	0	0	0	0	0	12.09	0	0
	2025	11	13	17	50	0	28	0	0	0	0	0	0	0	12.1	0	0
	2025	11	13	18	0	0	27	0	0	0	0	0	0	0	12.11	0	0
	2025	11	13	18	10	0	26	0	0	0	0	0	0	0	12.12	0	0
	2025	11	13	18	20	0	27	0	0	0	0	0	0	0	12.14	0	0
	2025	11	13	18	30	0	26	0	0	0	0	0	0	0	12.15	0	0
	2025	11	13	18	40	0	27	0	0	0	0	0	0	0	12.16	0	0
	2025	11	13	18	50	0	26	0	0	0	0	0	0	0	12.16	0	0
	2025	11	13	19	0	0	27	0	0	0	0	0	0	0	12.17	0	0
	2025	11	13	19	10	0	27	0	0	0	0	0	0	0	12.17	0	0
	2025	11	13	19	20	0	27	0	0	0	0	0	0	0	12.17	0	0
	2025	11	13	19	30	0	26	0	0	0	0	0	0	0	12.17	0	0
	2025	11	13	19	40	0	27	0	0	0	0	0	0	0	12.17	0	0
	2025	11	13	19	50	0	27	0	0	0	0	0	0	0	12.16	0	0
	2025	11	13	20	0	0	27	0	0	0	0	0	0	0	12.16	0	0
	2025	11	13	20	10	0	27	0	0	0	0	0	0	0	12.15	0	0
	2025	11	13	20	20	0	27	0	0	0	0	0	0	0	12.14	0	0
	2025	11	13	20	30	0	26	0	0	0	0	0	0	0	12.14	0	0
	2025	11	13	20	40	0	27	0	0	0	0	0	0	0	12.12	0	0
	2025	11	13	20	50	0	27	0	0	0	0	0	0	0	12.11	0	0
	2025	11	13	21	0	0	27	0	0	0	0	0	0	0	12.09	0	0
	2025	11	13	21	10	0	27	0	0	0	0	0	0	0	12.08	0	0
	2025	11	13	21	20	0	27	0	0	0	0	0	0	0	12.06	0	0
	2025	11	13	21	30	0	28	0	0	0	0	0	0	0	12.05	0	0
	2025	11	13	21	40	0	27	0	0	0	0	0	0	0	12.04	0	0
	2025	11	13	21	50	0	27	0	0	0	0	0	0	0	12.02	0	0
	2025	11	13	22	0	0	27	0	0	0	0	0	0	0	12.01	0	0
	2025	11	13	22	10	0	27	0	0	0	0	0	0	0	11.99	0	0
	2025	11	13	22	20	0	26	0	0	0	0	0	0	0	11.98	0	0
	2025	11	13	22	30	0	27	0	0	0	0	0	0	0	11.96	0	0
	2025	11	13	22	40	0	28	0	0	0	0	0	0	0	11.95	0	0
	2025	11	13	22	50	0	26	0	0	0	0	0	0	0	11.93	0	0
	2025	11	13	23	0	0	27	0	0	0	0	0	0	0	11.92	0	0
	2025	11	13	23	10	0	27	0	0	0	0	0	0	0	11.91	0	0
	2025	11	13	23	20	0	27	0	0	0	0	0	0	0	11.89	0	0
	2025	11	13	23	30	0	26	0	0	0	0	0	0	0	11.89	0	0
	2025	11	13	23	40	0	27	0	0	0	0	0	0	0	11.88	0	0
	2025	11	13	23	50	0	27	0	0	0	0	0	0	0	11.87	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	14	0	0	0	27	0	0	0	0	0	0	0	11.86	0	0
2025	11	14	0	10	0	27	0	0	0	0	0	0	0	11.85	0	0
2025	11	14	0	20	0	27	0	0	0	0	0	0	0	11.84	0	0
2025	11	14	0	30	0	27	0	0	0	0	0	0	0	11.82	0	0
2025	11	14	0	40	0	27	0	0	0	0	0	0	0	11.82	0	0
2025	11	14	0	50	0	26	0	0	0	0	0	0	0	11.8	0	0
2025	11	14	1	0	0	27	0	0	0	0	0	0	0	11.78	0	0
2025	11	14	1	10	0	27	0	0	0	0	0	0	0	11.77	0	0
2025	11	14	1	20	0	27	0	0	0	0	0	0	0	11.76	0	0
2025	11	14	1	30	0	27	0	0	0	0	0	0	0	11.74	0	0
2025	11	14	1	40	0	27	0	0	0	0	0	0	0	11.73	0	0
2025	11	14	1	50	0	27	0	0	0	0	0	0	0	11.71	0	0
2025	11	14	2	0	0	27	0	0	0	0	0	0	0	11.7	0	0
2025	11	14	2	10	0	27	0	0	0	0	0	0	0	11.68	0	0
2025	11	14	2	20	0	27	0	0	0	0	0	0	0	11.66	0	0
2025	11	14	2	30	0	27	0	0	0	0	0	0	0	11.65	0	0
2025	11	14	2	40	0	27	0	0	0	0	0	0	0	11.64	0	0
2025	11	14	2	50	0	27	0	0	0	0	0	0	0	11.62	0	0
2025	11	14	3	0	0	27	0	0	0	0	0	0	0	11.61	0	0
2025	11	14	3	10	0	27	0	0	0	0	0	0	0	11.6	0	0
2025	11	14	3	20	0	27	0	0	0	0	0	0	0	11.59	0	0
2025	11	14	3	30	0	27	0	0	0	0	0	0	0	11.58	0	0
2025	11	14	3	40	0	27	0	0	0	0	0	0	0	11.58	0	0
2025	11	14	3	50	0	27	0	0	0	0	0	0	0	11.57	0	0
2025	11	14	4	0	0	27	0	0	0	0	0	0	0	11.56	0	0
2025	11	14	4	10	0	26	0	0	0	0	0	0	0	11.55	0	0
2025	11	14	4	20	0	27	0	0	0	0	0	0	0	11.55	0	0
2025	11	14	4	30	0	27	0	0	0	0	0	0	0	11.54	0	0
2025	11	14	4	40	0	27	0	0	0	0	0	0	0	11.53	0	0
2025	11	14	4	50	0	26	0	0	0	0	0	0	0	11.52	0	0
2025	11	14	5	0	0	27	0	0	0	0	0	0	0	11.52	0	0
2025	11	14	5	10	0	27	0	0	0	0	0	0	0	11.5	0	0
2025	11	14	5	20	0	26	0	0	0	0	0	0	0	11.49	0	0
2025	11	14	5	30	0	27	0	0	0	0	0	0	0	11.49	0	0
2025	11	14	5	40	0	27	0	0	0	0	0	0	0	11.48	0	0
2025	11	14	5	50	0	28	0	0	0	0	0	0	0	11.47	0	0
2025	11	14	6	0	0	26	0	0	0	0	0	0	0	11.46	0	0
2025	11	14	6	10	0	27	0	0	0	0	0	0	0	11.45	0	0
2025	11	14	6	20	0	26	0	0	0	0	0	0	0	11.45	0	0
2025	11	14	6	30	0	27	0	0	0	0	0	0	0	11.44	0	0
2025	11	14	6	40	0	27	0	0	0	0	0	0	0	11.44	0	0
2025	11	14	6	50	0	27	0	0	0	0	0	0	0	11.44	0	0
2025	11	14	7	0	0	27	0	0	0	0	0	0	0	11.44	0	0
2025	11	14	7	10	0	27	0	0	0	0	0	0	0	11.44	0	0
2025	11	14	7	20	0	27	0	0	0	0	0	0	0	11.44	0	0
2025	11	14	7	30	0	27	0	0	0	0	0	0	0	11.44	0	0
2025	11	14	7	40	0	26	0	0	0	0	0	0	0	11.45	0	0
2025	11	14	7	50	0	27	0	0	0	0	0	0	0	11.45	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	14	8	0	0	27	0	0	0	0	0	0	0	11.46	0	0
2025	11	14	8	10	0	27	0	0	0	0	0	0	0	11.46	0	0
2025	11	14	8	20	0	27	0	0	0	0	0	0	0	11.47	0	0
2025	11	14	8	30	0	27	0	0	0	0	0	0	0	11.48	0	0
2025	11	14	8	40	0	27	0	0	0	0	0	0	0	11.48	0	0
2025	11	14	8	50	0	27	0	0	0	0	0	0	0	11.49	0	0
2025	11	14	9	0	0	27	0	0	0	0	0	0	0	11.51	0	0
2025	11	14	9	10	0	27	0	0	0	0	0	0	0	11.51	0	0
2025	11	14	9	20	0	27	0	0	0	0	0	0	0	11.52	0	0
2025	11	14	9	30	0	27	0	0	0	0	0	0	0	11.54	0	0
2025	11	14	9	40	0	27	0	0	0	0	0	0	0	11.55	0	0
2025	11	14	9	50	0	27	0	0	0	0	0	0	0	11.56	0	0
2025	11	14	10	0	0	28	0	0	0	0	0	0	0	11.57	0	0
2025	11	14	10	10	0	27	0	0	0	0	0	0	0	11.58	0	0
2025	11	14	10	20	0	27	0	0	0	0	0	0	0	11.59	0	0
2025	11	14	10	30	0	27	0	0	0	0	0	0	0	11.61	0	0
2025	11	14	10	40	0	27	0	0	0	0	0	0	0	11.62	0	0
2025	11	14	10	50	0	27	0	0	0	0	0	0	0	11.63	0	0
2025	11	14	11	0	0	27	0	0	0	0	0	0	0	11.64	0	0
2025	11	14	11	10	0	27	0	0	0	0	0	0	0	11.65	0	0
2025	11	14	11	20	0	27	0	0	0	0	0	0	0	11.66	0	0
2025	11	14	11	30	0	27	0	0	0	0	0	0	0	11.68	0	0
2025	11	14	11	40	0	27	0	0	0	0	0	0	0	11.7	0	0
2025	11	14	11	50	0	27	0	0	0	0	0	0	0	11.72	0	0
2025	11	14	12	0	0	27	0	0	0	0	0	0	0	11.75	0	0
2025	11	14	12	10	0	27	0	0	0	0	0	0	0	11.77	0	0
2025	11	14	12	20	0	27	0	0	0	0	0	0	0	11.79	0	0
2025	11	14	12	30	0	27	0	0	0	0	0	0	0	11.82	0	0
2025	11	14	12	40	0	27	0	0	0	0	0	0	0	11.84	0	0
2025	11	14	12	50	0	27	0	0	0	0	0	0	0	11.86	0	0
2025	11	14	13	0	0	27	0	0	0	0	0	0	0	11.89	0	0
2025	11	14	13	10	0	27	0	0	0	0	0	0	0	11.92	0	0
2025	11	14	13	20	0	27	0	0	0	0	0	0	0	11.95	0	0
2025	11	14	13	30	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	14	13	40	0	27	0	0	0	0	0	0	0	12	0	0
2025	11	14	13	50	0	27	0	0	0	0	0	0	0	12.03	0	0
2025	11	14	14	0	0	27	0	0	0	0	0	0	0	12.06	0	0
2025	11	14	14	10	0	27	0	0	0	0	0	0	0	12.08	0	0
2025	11	14	14	20	0	27	0	0	0	0	0	0	0	12.11	0	0
2025	11	14	14	30	0	27	0	0	0	0	0	0	0	12.14	0	0
2025	11	14	14	40	0	27	0	0	0	0	0	0	0	12.16	0	0
2025	11	14	14	50	0	27	0	0	0	0	0	0	0	12.17	0	0
2025	11	14	15	0	0	27	0	0	0	0	0	0	0	12.19	0	0
2025	11	14	15	10	0	27	0	0	0	0	0	0	0	12.2	0	0
2025	11	14	15	20	0	27	0	0	0	0	0	0	0	12.21	0	0
2025	11	14	15	30	0	27	0	0	0	0	0	0	0	12.23	0	0
2025	11	14	15	40	0	27	0	0	0	0	0	0	0	12.23	0	0
2025	11	14	15	50	0	27	0	0	0	0	0	0	0	12.24	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	11	14	16	0	0	27	0	0	0	0	0	0	0	12.25	0	0
	2025	11	14	16	10	0	27	0	0	0	0	0	0	0	12.26	0	0
	2025	11	14	16	20	0	27	0	0	0	0	0	0	0	12.26	0	0
	2025	11	14	16	30	0	26	0	0	0	0	0	0	0	12.27	0	0
	2025	11	14	16	40	0	27	0	0	0	0	0	0	0	12.27	0	0
	2025	11	14	16	50	0	27	0	0	0	0	0	0	0	12.26	0	0
	2025	11	14	17	0	0	27	0	0	0	0	0	0	0	12.26	0	0
	2025	11	14	17	10	0	27	0	0	0	0	0	0	0	12.27	0	0
	2025	11	14	17	20	0	27	0	0	0	0	0	0	0	12.26	0	0
	2025	11	14	17	30	0	27	0	0	0	0	0	0	0	12.26	0	0
	2025	11	14	17	40	0	27	0	0	0	0	0	0	0	12.26	0	0
	2025	11	14	17	50	0	27	0	0	0	0	0	0	0	12.25	0	0
	2025	11	14	18	0	0	27	0	0	0	0	0	0	0	12.24	0	0
	2025	11	14	18	10	0	27	0	0	0	0	0	0	0	12.24	0	0
	2025	11	14	18	20	0	27	0	0	0	0	0	0	0	12.24	0	0
	2025	11	14	18	30	0	27	0	0	0	0	0	0	0	12.23	0	0
	2025	11	14	18	40	0	26	0	0	0	0	0	0	0	12.24	0	0
	2025	11	14	18	50	0	27	0	0	0	0	0	0	0	12.23	0	0
	2025	11	14	19	0	0	27	0	0	0	0	0	0	0	12.23	0	0
	2025	11	14	19	10	0	27	0	0	0	0	0	0	0	12.22	0	0
	2025	11	14	19	20	0	27	0	0	0	0	0	0	0	12.22	0	0
	2025	11	14	19	30	0	27	0	0	0	0	0	0	0	12.21	0	0
	2025	11	14	19	40	0	27	0	0	0	0	0	0	0	12.21	0	0
	2025	11	14	19	50	0	27	0	0	0	0	0	0	0	12.2	0	0
	2025	11	14	20	0	0	27	0	0	0	0	0	0	0	12.2	0	0
	2025	11	14	20	10	0	27	0	0	0	0	0	0	0	12.19	0	0
	2025	11	14	20	20	0	27	0	0	0	0	0	0	0	12.19	0	0
	2025	11	14	20	30	0	27	0	0	0	0	0	0	0	12.18	0	0
	2025	11	14	20	40	0	27	0	0	0	0	0	0	0	12.17	0	0
	2025	11	14	20	50	0	26	0	0	0	0	0	0	0	12.16	0	0
	2025	11	14	21	0	0	27	0	0	0	0	0	0	0	12.16	0	0
	2025	11	14	21	10	0	27	0	0	0	0	0	0	0	12.15	0	0
	2025	11	14	21	20	0	27	0	0	0	0	0	0	0	12.15	0	0
	2025	11	14	21	30	0	27	0	0	0	0	0	0	0	12.14	0	0
	2025	11	14	21	40	0	27	0	0	0	0	0	0	0	12.13	0	0
	2025	11	14	21	50	0	27	0	0	0	0	0	0	0	12.12	0	0
	2025	11	14	22	0	0	27	0	0	0	0	0	0	0	12.11	0	0
	2025	11	14	22	10	0	27	0	0	0	0	0	0	0	12.1	0	0
	2025	11	14	22	20	0	27	0	0	0	0	0	0	0	12.09	0	0
	2025	11	14	22	30	0	27	0	0	0	0	0	0	0	12.09	0	0
	2025	11	14	22	40	0	26	0	0	0	0	0	0	0	12.08	0	0
	2025	11	14	22	50	0	27	0	0	0	0	0	0	0	12.07	0	0
	2025	11	14	23	0	0	27	0	0	0	0	0	0	0	12.07	0	0
	2025	11	14	23	10	0	27	0	0	0	0	0	0	0	12.06	0	0
	2025	11	14	23	20	0	27	0	0	0	0	0	0	0	12.05	0	0
	2025	11	14	23	30	0	27	0	0	0	0	0	0	0	12.04	0	0
	2025	11	14	23	40	0	27	0	0	0	0	0	0	0	12.03	0	0
	2025	11	14	23	50	0	27	0	0	0	0	0	0	0	12.02	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	15	0	0	0	27	0	0	0	0	0	0	0	12.02	0	0
2025	11	15	0	10	0	27	0	0	0	0	0	0	0	12.01	0	0
2025	11	15	0	20	0	27	0	0	0	0	0	0	0	12.01	0	0
2025	11	15	0	30	0	26	0	0	0	0	0	0	0	12	0	0
2025	11	15	0	40	0	27	0	0	0	0	0	0	0	12	0	0
2025	11	15	0	50	0	27	0	0	0	0	0	0	0	12	0	0
2025	11	15	1	0	0	27	0	0	0	0	0	0	0	11.99	0	0
2025	11	15	1	10	0	26	0	0	0	0	0	0	0	11.98	0	0
2025	11	15	1	20	0	27	0	0	0	0	0	0	0	11.98	0	0
2025	11	15	1	30	0	27	0	0	0	0	0	0	0	11.98	0	0
2025	11	15	1	40	0	26	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	1	50	0	28	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	2	0	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	2	10	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	2	20	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	2	30	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	2	40	0	27	0	0	0	0	0	0	0	11.96	0	0
2025	11	15	2	50	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	3	0	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	3	10	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	3	20	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	3	30	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	3	40	0	28	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	3	50	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	4	0	0	28	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	4	10	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	4	20	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	4	30	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	4	40	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	4	50	0	26	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	5	0	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	5	10	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	5	20	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	5	30	0	27	0	0	0	0	0	0	0	11.97	0	0
2025	11	15	5	40	0	28	0	0	0	0	0	0	0	11.98	0	0
2025	11	15	5	50	0	27	0	0	0	0	0	0	0	11.98	0	0
2025	11	15	6	0	0	27	0	0	0	0	0	0	0	11.99	0	0
2025	11	15	6	10	0	27	0	0	0	0	0	0	0	11.99	0	0
2025	11	15	6	20	0	27	0	0	0	0	0	0	0	12	0	0
2025	11	15	6	30	0	28	0	0	0	0	0	0	0	12	0	0
2025	11	15	6	40	0	28	0	0	0	0	0	0	0	12.01	0	0
2025	11	15	6	50	0	27	0	0	0	0	0	0	0	12.01	0	0
2025	11	15	7	0	0	27	0	0	0	0	0	0	0	12.02	0	0
2025	11	15	7	10	0	27	0	0	0	0	0	0	0	12.03	0	0
2025	11	15	7	20	0	28	0	0	0	0	0	0	0	12.03	0	0
2025	11	15	7	30	0	27	0	0	0	0	0	0	0	12.04	0	0
2025	11	15	7	40	0	27	0	0	0	0	0	0	0	12.05	0	0
2025	11	15	7	50	0	27	0	0	0	0	0	0	0	12.05	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	11	15	16	0	0	27	0	0	0	0	0	0	0	12.42	0	0
	2025	11	15	16	10	0	27	0	0	0	0	0	0	0	12.42	0	0
	2025	11	15	16	20	0	27	0	0	0	0	0	0	0	12.41	0	0
	2025	11	15	16	30	0	27	0	0	0	0	0	0	0	12.4	0	0
	2025	11	15	16	40	0	27	0	0	0	0	0	0	0	12.4	0	0
	2025	11	15	16	50	0	27	0	0	0	0	0	0	0	12.39	0	0
	2025	11	15	17	0	0	27	0	0	0	0	0	0	0	12.39	0	0
	2025	11	15	17	10	0	27	0	0	0	0	0	0	0	12.38	0	0
	2025	11	15	17	20	0	26	0	0	0	0	0	0	0	12.37	0	0
	2025	11	15	17	30	0	27	0	0	0	0	0	0	0	12.36	0	0
	2025	11	15	17	40	0	27	0	0	0	0	0	0	0	12.35	0	0
	2025	11	15	17	50	0	27	0	0	0	0	0	0	0	12.35	0	0
	2025	11	15	18	0	0	27	0	0	0	0	0	0	0	12.33	0	0
	2025	11	15	18	10	0	27	0	0	0	0	0	0	0	12.32	0	0
	2025	11	15	18	20	0	27	0	0	0	0	0	0	0	12.32	0	0
	2025	11	15	18	30	0	27	0	0	0	0	0	0	0	12.31	0	0
	2025	11	15	18	40	0	27	0	0	0	0	0	0	0	12.3	0	0
	2025	11	15	18	50	0	27	0	0	0	0	0	0	0	12.29	0	0
	2025	11	15	19	0	0	27	0	0	0	0	0	0	0	12.29	0	0
	2025	11	15	19	10	0	27	0	0	0	0	0	0	0	12.28	0	0
	2025	11	15	19	20	0	27	0	0	0	0	0	0	0	12.27	0	0
	2025	11	15	19	30	0	27	0	0	0	0	0	0	0	12.26	0	0
	2025	11	15	19	40	0	27	0	0	0	0	0	0	0	12.25	0	0
	2025	11	15	19	50	0	26	0	0	0	0	0	0	0	12.24	0	0
	2025	11	15	20	0	0	27	0	0	0	0	0	0	0	12.23	0	0
	2025	11	15	20	10	0	27	0	0	0	0	0	0	0	12.22	0	0
	2025	11	15	20	20	0	27	0	0	0	0	0	0	0	12.21	0	0
	2025	11	15	20	30	0	27	0	0	0	0	0	0	0	12.2	0	0
	2025	11	15	20	40	0	27	0	0	0	0	0	0	0	12.19	0	0
	2025	11	15	20	50	0	27	0	0	0	0	0	0	0	12.18	0	0
	2025	11	15	21	0	0	27	0	0	0	0	0	0	0	12.17	0	0
	2025	11	15	21	10	0	27	0	0	0	0	0	0	0	12.15	0	0
	2025	11	15	21	20	0	27	0	0	0	0	0	0	0	12.14	0	0
	2025	11	15	21	30	0	27	0	0	0	0	0	0	0	12.13	0	0
	2025	11	15	21	40	0	27	0	0	0	0	0	0	0	12.12	0	0
	2025	11	15	21	50	0	27	0	0	0	0	0	0	0	12.11	0	0
	2025	11	15	22	0	0	27	0	0	0	0	0	0	0	12.1	0	0
	2025	11	15	22	10	0	27	0	0	0	0	0	0	0	12.08	0	0
	2025	11	15	22	20	0	26	0	0	0	0	0	0	0	12.07	0	0
	2025	11	15	22	30	0	27	0	0	0	0	0	0	0	12.06	0	0
	2025	11	15	22	40	0	27	0	0	0	0	0	0	0	12.05	0	0
	2025	11	15	22	50	0	28	0	0	0	0	0	0	0	12.04	0	0
	2025	11	15	23	0	0	27	0	0	0	0	0	0	0	12.02	0	0
	2025	11	15	23	10	0	27	0	0	0	0	0	0	0	12.02	0	0
	2025	11	15	23	20	0	28	0	0	0	0	0	0	0	12	0	0
	2025	11	15	23	30	0	27	0	0	0	0	0	0	0	11.99	0	0
	2025	11	15	23	40	0	27	0	0	0	0	0	0	0	11.98	0	0
	2025	11	15	23	50	0	27	0	0	0	0	0	0	0	11.97	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	16	8	0	0	27	0	0	0	0	0	0	0	11.43	0	0
2025	11	16	8	10	0	28	0	0	0	0	0	0	0	11.43	0	0
2025	11	16	8	20	0	27	0	0	0	0	0	0	0	11.41	0	0
2025	11	16	8	30	0	27	0	0	0	0	0	0	0	11.4	0	0
2025	11	16	8	40	0	27	0	0	0	0	0	0	0	11.38	0	0
2025	11	16	8	50	0	27	0	0	0	0	0	0	0	11.37	0	0
2025	11	16	9	0	0	27	0	0	0	0	0	0	0	11.36	0	0
2025	11	16	9	10	0	27	0	0	0	0	0	0	0	11.35	0	0
2025	11	16	9	20	0	26	0	0	0	0	0	0	0	11.34	0	0
2025	11	16	9	30	0	27	0	0	0	0	0	0	0	11.32	0	0
2025	11	16	9	40	0	26	0	0	0	0	0	0	0	11.31	0	0
2025	11	16	9	50	0	27	0	0	0	0	0	0	0	11.29	0	0
2025	11	16	10	0	0	27	0	0	0	0	0	0	0	11.28	0	0
2025	11	16	10	10	0	26	0	0	0	0	0	0	0	11.27	0	0
2025	11	16	10	20	0	26	0	0	0	0	0	0	0	11.27	0	0
2025	11	16	10	30	0	26	0	0	0	0	0	0	0	11.26	0	0
2025	11	16	10	40	0	26	0	0	0	0	0	0	0	11.26	0	0
2025	11	16	10	50	0	28	0	0	0	0	0	0	0	11.26	0	0
2025	11	16	11	0	0	27	0	0	0	0	0	0	0	11.25	0	0
2025	11	16	11	10	0	27	0	0	0	0	0	0	0	11.25	0	0
2025	11	16	11	20	0	27	0	0	0	0	0	0	0	11.25	0	0
2025	11	16	11	30	0	27	0	0	0	0	0	0	0	11.26	0	0
2025	11	16	11	40	0	27	0	0	0	0	0	0	0	11.26	0	0
2025	11	16	11	50	0	27	0	0	0	0	0	0	0	11.27	0	0
2025	11	16	12	0	0	27	0	0	0	0	0	0	0	11.28	0	0
2025	11	16	12	10	0	27	0	0	0	0	0	0	0	11.3	0	0
2025	11	16	12	20	0	27	0	0	0	0	0	0	0	11.32	0	0
2025	11	16	12	30	0	27	0	0	0	0	0	0	0	11.33	0	0
2025	11	16	12	40	0	27	0	0	0	0	0	0	0	11.34	0	0
2025	11	16	12	50	0	27	0	0	0	0	0	0	0	11.34	0	0
2025	11	16	13	0	0	27	0	0	0	0	0	0	0	11.35	0	0
2025	11	16	13	10	0	27	0	0	0	0	0	0	0	11.36	0	0
2025	11	16	13	20	0	27	0	0	0	0	0	0	0	11.38	0	0
2025	11	16	13	30	0	27	0	0	0	0	0	0	0	11.4	0	0
2025	11	16	13	40	0	27	0	0	0	0	0	0	0	11.42	0	0
2025	11	16	13	50	0	26	0	0	0	0	0	0	0	11.44	0	0
2025	11	16	14	0	0	27	0	0	0	0	0	0	0	11.44	0	0
2025	11	16	14	10	0	27	0	0	0	0	0	0	0	11.45	0	0
2025	11	16	14	20	0	27	0	0	0	0	0	0	0	11.46	0	0
2025	11	16	14	30	0	27	0	0	0	0	0	0	0	11.47	0	0
2025	11	16	14	40	0	27	0	0	0	0	0	0	0	11.48	0	0
2025	11	16	14	50	0	27	0	0	0	0	0	0	0	11.49	0	0
2025	11	16	15	0	0	27	0	0	0	0	0	0	0	11.51	0	0
2025	11	16	15	10	0	27	0	0	0	0	0	0	0	11.53	0	0
2025	11	16	15	20	0	27	0	0	0	0	0	0	0	11.54	0	0
2025	11	16	15	30	0	28	0	0	0	0	0	0	0	11.55	0	0
2025	11	16	15	40	0	27	0	0	0	0	0	0	0	11.57	0	0
2025	11	16	15	50	0	27	0	0	0	0	0	0	0	11.58	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	17	0	0	0	27	0	0	0	0	0	0	0	10.78	0	0
2025	11	17	0	10	0	27	0	0	0	0	0	0	0	10.75	0	0
2025	11	17	0	20	0	27	0	0	0	0	0	0	0	10.71	0	0
2025	11	17	0	30	0	27	0	0	0	0	0	0	0	10.68	0	0
2025	11	17	0	40	0	28	0	0	0	0	0	0	0	10.65	0	0
2025	11	17	0	50	0	27	0	0	0	0	0	0	0	10.61	0	0
2025	11	17	1	0	0	27	0	0	0	0	0	0	0	10.58	0	0
2025	11	17	1	10	0	27	0	0	0	0	0	0	0	10.55	0	0
2025	11	17	1	20	0	27	0	0	0	0	0	0	0	10.51	0	0
2025	11	17	1	30	0	27	0	0	0	0	0	0	0	10.48	0	0
2025	11	17	1	40	0	27	0	0	0	0	0	0	0	10.45	0	0
2025	11	17	1	50	0	28	0	0	0	0	0	0	0	10.42	0	0
2025	11	17	2	0	0	27	0	0	0	0	0	0	0	10.39	0	0
2025	11	17	2	10	0	27	0	0	0	0	0	0	0	10.37	0	0
2025	11	17	2	20	0	27	0	0	0	0	0	0	0	10.34	0	0
2025	11	17	2	30	0	27	0	0	0	0	0	0	0	10.31	0	0
2025	11	17	2	40	0	27	0	0	0	0	0	0	0	10.28	0	0
2025	11	17	2	50	0	27	0	0	0	0	0	0	0	10.26	0	0
2025	11	17	3	0	0	27	0	0	0	0	0	0	0	10.23	0	0
2025	11	17	3	10	0	27	0	0	0	0	0	0	0	10.2	0	0
2025	11	17	3	20	0	27	0	0	0	0	0	0	0	10.18	0	0
2025	11	17	3	30	0	27	0	0	0	0	0	0	0	10.14	0	0
2025	11	17	3	40	0	27	0	0	0	0	0	0	0	10.12	0	0
2025	11	17	3	50	0	27	0	0	0	0	0	0	0	10.09	0	0
2025	11	17	4	0	0	27	0	0	0	0	0	0	0	10.06	0	0
2025	11	17	4	10	0	27	0	0	0	0	0	0	0	10.03	0	0
2025	11	17	4	20	0	27	0	0	0	0	0	0	0	10.01	0	0
2025	11	17	4	30	0	27	0	0	0	0	0	0	0	9.98	0	0
2025	11	17	4	40	0	27	0	0	0	0	0	0	0	9.95	0	0
2025	11	17	4	50	0	27	0	0	0	0	0	0	0	9.92	0	0
2025	11	17	5	0	0	27	0	0	0	0	0	0	0	9.9	0	0
2025	11	17	5	10	0	27	0	0	0	0	0	0	0	9.87	0	0
2025	11	17	5	20	0	27	0	0	0	0	0	0	0	9.84	0	0
2025	11	17	5	30	0	27	0	0	0	0	0	0	0	9.81	0	0
2025	11	17	5	40	0	27	0	0	0	0	0	0	0	9.79	0	0
2025	11	17	5	50	0	27	0	0	0	0	0	0	0	9.75	0	0
2025	11	17	6	0	0	27	0	0	0	0	0	0	0	9.73	0	0
2025	11	17	6	10	0	27	0	0	0	0	0	0	0	9.7	0	0
2025	11	17	6	20	0	28	0	0	0	0	0	0	0	9.68	0	0
2025	11	17	6	30	0	28	0	0	0	0	0	0	0	9.65	0	0
2025	11	17	6	40	0	27	0	0	0	0	0	0	0	9.63	0	0
2025	11	17	6	50	0	27	0	0	0	0	0	0	0	9.61	0	0
2025	11	17	7	0	0	27	0	0	0	0	0	0	0	9.58	0	0
2025	11	17	7	10	0	28	0	0	0	0	0	0	0	9.56	0	0
2025	11	17	7	20	0	27	0	0	0	0	0	0	0	9.54	0	0
2025	11	17	7	30	0	28	0	0	0	0	0	0	0	9.51	0	0
2025	11	17	7	40	0	28	0	0	0	0	0	0	0	9.5	0	0
2025	11	17	7	50	0	28	0	0	0	0	0	0	0	9.48	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	17	8	0	0	27	0	0	0	0	0	0	0	9.46	0	0
2025	11	17	8	10	0	27	0	0	0	0	0	0	0	9.44	0	0
2025	11	17	8	20	0	27	0	0	0	0	0	0	0	9.42	0	0
2025	11	17	8	30	0	28	0	0	0	0	0	0	0	9.41	0	0
2025	11	17	8	40	0	28	0	0	0	0	0	0	0	9.4	0	0
2025	11	17	8	50	0	28	0	0	0	0	0	0	0	9.39	0	0
2025	11	17	9	0	0	27	0	0	0	0	0	0	0	9.39	0	0
2025	11	17	9	10	0	27	0	0	0	0	0	0	0	9.4	0	0
2025	11	17	9	20	0	27	0	0	0	0	0	0	0	9.4	0	0
2025	11	17	9	30	0	27	0	0	0	0	0	0	0	9.41	0	0
2025	11	17	9	40	0	27	0	0	0	0	0	0	0	9.42	0	0
2025	11	17	9	50	0	28	0	0	0	0	0	0	0	9.43	0	0
2025	11	17	10	0	0	28	0	0	0	0	0	0	0	9.45	0	0
2025	11	17	10	10	0	28	0	0	0	0	0	0	0	9.46	0	0
2025	11	17	10	20	0	27	0	0	0	0	0	0	0	9.47	0	0
2025	11	17	10	30	0	27	0	0	0	0	0	0	0	9.5	0	0
2025	11	17	10	40	0	27	0	0	0	0	0	0	0	9.52	0	0
2025	11	17	10	50	0	28	0	0	0	0	0	0	0	9.54	0	0
2025	11	17	11	0	0	27	0	0	0	0	0	0	0	9.56	0	0
2025	11	17	11	10	0	27	0	0	0	0	0	0	0	9.57	0	0
2025	11	17	11	20	0	28	0	0	0	0	0	0	0	9.6	0	0
2025	11	17	11	30	0	27	0	0	0	0	0	0	0	9.61	0	0
2025	11	17	11	40	0	28	0	0	0	0	0	0	0	9.63	0	0
2025	11	17	11	50	0	28	0	0	0	0	0	0	0	9.65	0	0
2025	11	17	12	0	0	27	0	0	0	0	0	0	0	9.66	0	0
2025	11	17	12	10	0	28	0	0	0	0	0	0	0	9.68	0	0
2025	11	17	12	20	0	28	0	0	0	0	0	0	0	9.7	0	0
2025	11	17	12	30	0	28	0	0	0	0	0	0	0	9.72	0	0
2025	11	17	12	40	0	27	0	0	0	0	0	0	0	9.73	0	0
2025	11	17	12	50	0	28	0	0	0	0	0	0	0	9.74	0	0
2025	11	17	13	0	0	27	0	0	0	0	0	0	0	9.75	0	0
2025	11	17	13	10	0	27	0	0	0	0	0	0	0	9.76	0	0
2025	11	17	13	20	0	27	0	0	0	0	0	0	0	9.77	0	0
2025	11	17	13	30	0	27	0	0	0	0	0	0	0	9.78	0	0
2025	11	17	13	40	0	27	0	0	0	0	0	0	0	9.8	0	0
2025	11	17	13	50	0	27	0	0	0	0	0	0	0	9.8	0	0
2025	11	17	14	0	0	27	0	0	0	0	0	0	0	9.81	0	0
2025	11	17	14	10	0	27	0	0	0	0	0	0	0	9.82	0	0
2025	11	17	14	20	0	28	0	0	0	0	0	0	0	9.83	0	0
2025	11	17	14	30	0	28	0	0	0	0	0	0	0	9.83	0	0
2025	11	17	14	40	0	27	0	0	0	0	0	0	0	9.85	0	0
2025	11	17	14	50	0	27	0	0	0	0	0	0	0	9.85	0	0
2025	11	17	15	0	0	28	0	0	0	0	0	0	0	9.87	0	0
2025	11	17	15	10	0	27	0	0	0	0	0	0	0	9.87	0	0
2025	11	17	15	20	0	27	0	0	0	0	0	0	0	9.88	0	0
2025	11	17	15	30	0	27	0	0	0	0	0	0	0	9.89	0	0
2025	11	17	15	40	0	27	0	0	0	0	0	0	0	9.89	0	0
2025	11	17	15	50	0	27	0	0	0	0	0	0	0	9.9	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	18	0	0	0	27	0	0	0	0	0	0	0	9.69	0	0
2025	11	18	0	10	0	27	0	0	0	0	0	0	0	9.69	0	0
2025	11	18	0	20	0	27	0	0	0	0	0	0	0	9.68	0	0
2025	11	18	0	30	0	27	0	0	0	0	0	0	0	9.67	0	0
2025	11	18	0	40	0	28	0	0	0	0	0	0	0	9.66	0	0
2025	11	18	0	50	0	27	0	0	0	0	0	0	0	9.66	0	0
2025	11	18	1	0	0	27	0	0	0	0	0	0	0	9.65	0	0
2025	11	18	1	10	0	28	0	0	0	0	0	0	0	9.64	0	0
2025	11	18	1	20	0	27	0	0	0	0	0	0	0	9.62	0	0
2025	11	18	1	30	0	27	0	0	0	0	0	0	0	9.61	0	0
2025	11	18	1	40	0	27	0	0	0	0	0	0	0	9.59	0	0
2025	11	18	1	50	0	27	0	0	0	0	0	0	0	9.57	0	0
2025	11	18	2	0	0	27	0	0	0	0	0	0	0	9.55	0	0
2025	11	18	2	10	0	27	0	0	0	0	0	0	0	9.53	0	0
2025	11	18	2	20	0	28	0	0	0	0	0	0	0	9.5	0	0
2025	11	18	2	30	0	27	0	0	0	0	0	0	0	9.48	0	0
2025	11	18	2	40	0	27	0	0	0	0	0	0	0	9.46	0	0
2025	11	18	2	50	0	28	0	0	0	0	0	0	0	9.44	0	0
2025	11	18	3	0	0	28	0	0	0	0	0	0	0	9.41	0	0
2025	11	18	3	10	0	28	0	0	0	0	0	0	0	9.39	0	0
2025	11	18	3	20	0	27	0	0	0	0	0	0	0	9.37	0	0
2025	11	18	3	30	0	28	0	0	0	0	0	0	0	9.35	0	0
2025	11	18	3	40	0	28	0	0	0	0	0	0	0	9.33	0	0
2025	11	18	3	50	0	28	0	0	0	0	0	0	0	9.31	0	0
2025	11	18	4	0	0	28	0	0	0	0	0	0	0	9.29	0	0
2025	11	18	4	10	0	28	0	0	0	0	0	0	0	9.28	0	0
2025	11	18	4	20	0	27	0	0	0	0	0	0	0	9.26	0	0
2025	11	18	4	30	0	27	0	0	0	0	0	0	0	9.25	0	0
2025	11	18	4	40	0	28	0	0	0	0	0	0	0	9.23	0	0
2025	11	18	4	50	0	27	0	0	0	0	0	0	0	9.22	0	0
2025	11	18	5	0	0	28	0	0	0	0	0	0	0	9.21	0	0
2025	11	18	5	10	0	28	0	0	0	0	0	0	0	9.2	0	0
2025	11	18	5	20	0	27	0	0	0	0	0	0	0	9.19	0	0
2025	11	18	5	30	0	27	0	0	0	0	0	0	0	9.18	0	0
2025	11	18	5	40	0	27	0	0	0	0	0	0	0	9.17	0	0
2025	11	18	5	50	0	27	0	0	0	0	0	0	0	9.16	0	0
2025	11	18	6	0	0	28	0	0	0	0	0	0	0	9.15	0	0
2025	11	18	6	10	0	28	0	0	0	0	0	0	0	9.14	0	0
2025	11	18	6	20	0	28	0	0	0	0	0	0	0	9.13	0	0
2025	11	18	6	30	0	27	0	0	0	0	0	0	0	9.12	0	0
2025	11	18	6	40	0	28	0	0	0	0	0	0	0	9.1	0	0
2025	11	18	6	50	0	27	0	0	0	0	0	0	0	9.09	0	0
2025	11	18	7	0	0	28	0	0	0	0	0	0	0	9.08	0	0
2025	11	18	7	10	0	27	0	0	0	0	0	0	0	9.06	0	0
2025	11	18	7	20	0	27	0	0	0	0	0	0	0	9.05	0	0
2025	11	18	7	30	0	28	0	0	0	0	0	0	0	9.04	0	0
2025	11	18	7	40	0	28	0	0	0	0	0	0	0	9.02	0	0
2025	11	18	7	50	0	27	0	0	0	0	0	0	0	9.01	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	18	8	0	0	28	0	0	0	0	0	0	0	9	0	0
2025	11	18	8	10	0	28	0	0	0	0	0	0	0	8.98	0	0
2025	11	18	8	20	0	27	0	0	0	0	0	0	0	8.97	0	0
2025	11	18	8	30	0	28	0	0	0	0	0	0	0	8.96	0	0
2025	11	18	8	40	0	27	0	0	0	0	0	0	0	8.96	0	0
2025	11	18	8	50	0	27	0	0	0	0	0	0	0	8.95	0	0
2025	11	18	9	0	0	28	0	0	0	0	0	0	0	8.95	0	0
2025	11	18	9	10	0	27	0	0	0	0	0	0	0	8.94	0	0
2025	11	18	9	20	0	27	0	0	0	0	0	0	0	8.94	0	0
2025	11	18	9	30	0	27	0	0	0	0	0	0	0	8.93	0	0
2025	11	18	9	40	0	27	0	0	0	0	0	0	0	8.93	0	0
2025	11	18	9	50	0	27	0	0	0	0	0	0	0	8.93	0	0
2025	11	18	10	0	0	27	0	0	0	0	0	0	0	8.93	0	0
2025	11	18	10	10	0	28	0	0	0	0	0	0	0	8.93	0	0
2025	11	18	10	20	0	28	0	0	0	0	0	0	0	8.93	0	0
2025	11	18	10	30	0	27	0	0	0	0	0	0	0	8.94	0	0
2025	11	18	10	40	0	27	0	0	0	0	0	0	0	8.95	0	0
2025	11	18	10	50	0	27	0	0	0	0	0	0	0	8.95	0	0
2025	11	18	11	0	0	27	0	0	0	0	0	0	0	8.96	0	0
2025	11	18	11	10	0	27	0	0	0	0	0	0	0	8.96	0	0
2025	11	18	11	20	0	27	0	0	0	0	0	0	0	8.97	0	0
2025	11	18	11	30	0	28	0	0	0	0	0	0	0	8.97	0	0
2025	11	18	11	40	0	28	0	0	0	0	0	0	0	8.97	0	0
2025	11	18	11	50	0	28	0	0	0	0	0	0	0	8.98	0	0
2025	11	18	12	0	0	27	0	0	0	0	0	0	0	8.98	0	0
2025	11	18	12	10	0	27	0	0	0	0	0	0	0	9.01	0	0
2025	11	18	12	20	0	27	0	0	0	0	0	0	0	9.02	0	0
2025	11	18	12	30	0	28	0	0	0	0	0	0	0	9.03	0	0
2025	11	18	12	40	0	27	0	0	0	0	0	0	0	9.06	0	0
2025	11	18	12	50	0	27	0	0	0	0	0	0	0	9.11	0	0
2025	11	18	13	0	0	28	0	0	0	0	0	0	0	9.12	0	0
2025	11	18	13	10	0	27	0	0	0	0	0	0	0	9.13	0	0
2025	11	18	13	20	0	28	0	0	0	0	0	0	0	9.13	0	0
2025	11	18	13	30	0	27	0	0	0	0	0	0	0	9.13	0	0
2025	11	18	13	40	0	28	0	0	0	0	0	0	0	9.14	0	0
2025	11	18	13	50	0	28	0	0	0	0	0	0	0	9.16	0	0
2025	11	18	14	1	10	27	0	0	0	0	0	0	0	9.16	0	0
2025	11	18	14	11	10	27	0	0	0	0	0	0	0	9.16	0	0
2025	11	18	14	21	10	28	0	0	0	0	0	0	0	9.16	0	0
2025	11	18	14	31	10	28	0	0	0	0	0	0	0	9.17	0	0
2025	11	18	14	41	10	27	0	0	0	0	0	0	0	9.17	0	0
2025	11	18	14	51	10	27	0	0	0	0	0	0	0	9.17	0	0
2025	11	18	15	1	10	27	0	0	0	0	0	0	0	9.17	0	0
2025	11	18	15	11	10	27	0	0	0	0	0	0	0	9.17	0	0
2025	11	18	15	21	10	28	0	0	0	0	0	0	0	9.17	0	0
2025	11	18	15	31	10	28	0	0	0	0	0	0	0	9.18	0	0
2025	11	18	15	41	10	27	0	0	0	0	0	0	0	9.19	0	0
2025	11	18	15	51	10	28	0	0	0	0	0	0	0	9.19	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	11	18	16	1	10	28	0	0	0	0	0	0	0	9.2	0	0
	2025	11	18	16	11	10	27	0	0	0	0	0	0	0	9.2	0	0
	2025	11	18	16	21	10	27	0	0	0	0	0	0	0	9.19	0	0
	2025	11	18	16	31	10	28	0	0	0	0	0	0	0	9.19	0	0
	2025	11	18	16	41	10	27	0	0	0	0	0	0	0	9.19	0	0
	2025	11	18	16	51	10	28	0	0	0	0	0	0	0	9.18	0	0
	2025	11	18	17	1	10	27	0	0	0	0	0	0	0	9.18	0	0
	2025	11	18	17	11	10	27	0	0	0	0	0	0	0	9.18	0	0
	2025	11	18	17	21	10	28	0	0	0	0	0	0	0	9.18	0	0
	2025	11	18	17	31	10	27	0	0	0	0	0	0	0	9.17	0	0
	2025	11	18	17	41	10	27	0	0	0	0	0	0	0	9.17	0	0
	2025	11	18	17	51	10	28	0	0	0	0	0	0	0	9.17	0	0
	2025	11	18	18	1	10	28	0	0	0	0	0	0	0	9.16	0	0
	2025	11	18	18	11	10	27	0	0	0	0	0	0	0	9.16	0	0
	2025	11	18	18	21	10	28	0	0	0	0	0	0	0	9.15	0	0
	2025	11	18	18	31	10	27	0	0	0	0	0	0	0	9.14	0	0
	2025	11	18	18	41	10	27	0	0	0	0	0	0	0	9.13	0	0
	2025	11	18	18	51	10	28	0	0	0	0	0	0	0	9.12	0	0
	2025	11	18	19	1	10	28	0	0	0	0	0	0	0	9.11	0	0
	2025	11	18	19	11	10	28	0	0	0	0	0	0	0	9.09	0	0
	2025	11	18	19	21	10	27	0	0	0	0	0	0	0	9.07	0	0
	2025	11	18	19	31	10	28	0	0	0	0	0	0	0	9.06	0	0
	2025	11	18	19	41	10	27	0	0	0	0	0	0	0	9.04	0	0
	2025	11	18	19	51	10	28	0	0	0	0	0	0	0	9.03	0	0
	2025	11	18	20	1	10	27	0	0	0	0	0	0	0	9.01	0	0
	2025	11	18	20	11	10	27	0	0	0	0	0	0	0	9	0	0
	2025	11	18	20	21	10	28	0	0	0	0	0	0	0	8.98	0	0
	2025	11	18	20	31	10	27	0	0	0	0	0	0	0	8.97	0	0
	2025	11	18	20	41	10	27	0	0	0	0	0	0	0	8.95	0	0
	2025	11	18	20	51	10	28	0	0	0	0	0	0	0	8.94	0	0
	2025	11	18	21	1	10	28	0	0	0	0	0	0	0	8.92	0	0
	2025	11	18	21	11	10	27	0	0	0	0	0	0	0	8.92	0	0
	2025	11	18	21	21	10	28	0	0	0	0	0	0	0	8.9	0	0
	2025	11	18	21	31	10	27	0	0	0	0	0	0	0	8.89	0	0
	2025	11	18	21	41	10	28	0	0	0	0	0	0	0	8.88	0	0
	2025	11	18	21	51	10	28	0	0	0	0	0	0	0	8.87	0	0
	2025	11	18	22	1	10	28	0	0	0	0	0	0	0	8.86	0	0
	2025	11	18	22	11	10	27	0	0	0	0	0	0	0	8.84	0	0
	2025	11	18	22	21	10	27	0	0	0	0	0	0	0	8.83	0	0
	2025	11	18	22	31	10	27	0	0	0	0	0	0	0	8.82	0	0
	2025	11	18	22	41	10	28	0	0	0	0	0	0	0	8.81	0	0
	2025	11	18	22	51	10	28	0	0	0	0	0	0	0	8.81	0	0
	2025	11	18	23	1	10	28	0	0	0	0	0	0	0	8.8	0	0
	2025	11	18	23	11	10	28	0	0	0	0	0	0	0	8.79	0	0
	2025	11	18	23	21	10	27	0	0	0	0	0	0	0	8.78	0	0
	2025	11	18	23	31	10	28	0	0	0	0	0	0	0	8.77	0	0
	2025	11	18	23	41	10	28	0	0	0	0	0	0	0	8.76	0	0
	2025	11	18	23	51	10	27	0	0	0	0	0	0	0	8.75	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	19	8	1	10	27	0	0	0	0	0	0	0	8.27	0	0
2025	11	19	8	11	10	28	0	0	0	0	0	0	0	8.26	0	0
2025	11	19	8	21	10	28	0	0	0	0	0	0	0	8.25	0	0
2025	11	19	8	31	10	28	0	0	0	0	0	0	0	8.24	0	0
2025	11	19	8	41	10	27	0	0	0	0	0	0	0	8.23	0	0
2025	11	19	8	51	10	27	0	0	0	0	0	0	0	8.23	0	0
2025	11	19	9	1	10	27	0	0	0	0	0	0	0	8.23	0	0
2025	11	19	9	11	10	27	0	0	0	0	0	0	0	8.23	0	0
2025	11	19	9	21	10	28	0	0	0	0	0	0	0	8.22	0	0
2025	11	19	9	31	10	27	0	0	0	0	0	0	0	8.22	0	0
2025	11	19	9	41	10	28	0	0	0	0	0	0	0	8.23	0	0
2025	11	19	9	51	10	29	0	0	0	0	0	0	0	8.23	0	0
2025	11	19	10	1	10	28	0	0	0	0	0	0	0	8.23	0	0
2025	11	19	10	11	10	28	0	0	0	0	0	0	0	8.25	0	0
2025	11	19	10	21	10	27	0	0	0	0	0	0	0	8.26	0	0
2025	11	19	10	31	10	27	0	0	0	0	0	0	0	8.27	0	0
2025	11	19	10	41	10	28	0	0	0	0	0	0	0	8.29	0	0
2025	11	19	10	51	10	28	0	0	0	0	0	0	0	8.31	0	0
2025	11	19	11	1	10	28	0	0	0	0	0	0	0	8.33	0	0
2025	11	19	11	11	10	27	0	0	0	0	0	0	0	8.35	0	0
2025	11	19	11	21	10	28	0	0	0	0	0	0	0	8.37	0	0
2025	11	19	11	31	10	27	0	0	0	0	0	0	0	8.39	0	0
2025	11	19	11	41	10	28	0	0	0	0	0	0	0	8.42	0	0
2025	11	19	11	51	10	27	0	0	0	0	0	0	0	8.44	0	0
2025	11	19	12	1	10	28	0	0	0	0	0	0	0	8.48	0	0
2025	11	19	12	11	10	27	0	0	0	0	0	0	0	8.51	0	0
2025	11	19	12	21	10	28	0	0	0	0	0	0	0	8.53	0	0
2025	11	19	12	31	10	28	0	0	0	0	0	0	0	8.55	0	0
2025	11	19	12	41	10	28	0	0	0	0	0	0	0	8.59	0	0
2025	11	19	12	51	10	27	0	0	0	0	0	0	0	8.62	0	0
2025	11	19	13	1	10	27	0	0	0	0	0	0	0	8.65	0	0
2025	11	19	13	11	10	27	0	0	0	0	0	0	0	8.69	0	0
2025	11	19	13	21	10	27	0	0	0	0	0	0	0	8.7	0	0
2025	11	19	13	31	10	27	0	0	0	0	0	0	0	8.73	0	0
2025	11	19	13	41	10	27	0	0	0	0	0	0	0	8.76	0	0
2025	11	19	13	51	10	27	0	0	0	0	0	0	0	8.78	0	0
2025	11	19	14	1	10	27	0	0	0	0	0	0	0	8.81	0	0
2025	11	19	14	11	10	27	0	0	0	0	0	0	0	8.86	0	0
2025	11	19	14	21	10	28	0	0	0	0	0	0	0	8.9	0	0
2025	11	19	14	31	10	27	0	0	0	0	0	0	0	8.95	0	0
2025	11	19	14	41	10	27	0	0	0	0	0	0	0	9.01	0	0
2025	11	19	14	51	10	28	0	0	0	0	0	0	0	9.07	0	0
2025	11	19	15	1	10	27	0	0	0	0	0	0	0	9.11	0	0
2025	11	19	15	11	10	27	0	0	0	0	0	0	0	9.15	0	0
2025	11	19	15	21	10	28	0	0	0	0	0	0	0	9.21	0	0
2025	11	19	15	31	10	27	0	0	0	0	0	0	0	9.26	0	0
2025	11	19	15	41	10	27	0	0	0	0	0	0	0	9.31	0	0
2025	11	19	15	51	10	27	0	0	0	0	0	0	0	9.34	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	11	19	16	1	10	27	0	0	0	0	0	0	0	9.38	0	0
	2025	11	19	16	11	10	28	0	0	0	0	0	0	0	9.41	0	0
	2025	11	19	16	21	10	27	0	0	0	0	0	0	0	9.45	0	0
	2025	11	19	16	31	10	28	0	0	0	0	0	0	0	9.48	0	0
	2025	11	19	16	41	10	28	0	0	0	0	0	0	0	9.52	0	0
	2025	11	19	16	51	10	27	0	0	0	0	0	0	0	9.55	0	0
	2025	11	19	17	1	10	27	0	0	0	0	0	0	0	9.57	0	0
	2025	11	19	17	11	10	27	0	0	0	0	0	0	0	9.6	0	0
	2025	11	19	17	21	10	28	0	0	0	0	0	0	0	9.62	0	0
	2025	11	19	17	31	10	28	0	0	0	0	0	0	0	9.63	0	0
	2025	11	19	17	41	10	28	0	0	0	0	0	0	0	9.65	0	0
	2025	11	19	17	51	10	27	0	0	0	0	0	0	0	9.65	0	0
	2025	11	19	18	1	10	28	0	0	0	0	0	0	0	9.66	0	0
	2025	11	19	18	11	10	27	0	0	0	0	0	0	0	9.67	0	0
	2025	11	19	18	21	10	28	0	0	0	0	0	0	0	9.67	0	0
	2025	11	19	18	31	10	28	0	0	0	0	0	0	0	9.66	0	0
	2025	11	19	18	41	10	27	0	0	0	0	0	0	0	9.66	0	0
	2025	11	19	18	51	10	27	0	0	0	0	0	0	0	9.66	0	0
	2025	11	19	19	1	10	27	0	0	0	0	0	0	0	9.64	0	0
	2025	11	19	19	11	10	27	0	0	0	0	0	0	0	9.63	0	0
	2025	11	19	19	21	10	28	0	0	0	0	0	0	0	9.61	0	0
	2025	11	19	19	31	10	27	0	0	0	0	0	0	0	9.59	0	0
	2025	11	19	19	41	10	27	0	0	0	0	0	0	0	9.57	0	0
	2025	11	19	19	51	10	27	0	0	0	0	0	0	0	9.55	0	0
	2025	11	19	20	1	10	28	0	0	0	0	0	0	0	9.52	0	0
	2025	11	19	20	11	10	27	0	0	0	0	0	0	0	9.49	0	0
	2025	11	19	20	21	10	28	0	0	0	0	0	0	0	9.46	0	0
	2025	11	19	20	31	10	27	0	0	0	0	0	0	0	9.43	0	0
	2025	11	19	20	41	10	28	0	0	0	0	0	0	0	9.38	0	0
	2025	11	19	20	51	10	27	0	0	0	0	0	0	0	9.35	0	0
	2025	11	19	21	1	10	28	0	0	0	0	0	0	0	9.3	0	0
	2025	11	19	21	11	10	28	0	0	0	0	0	0	0	9.26	0	0
	2025	11	19	21	21	10	28	0	0	0	0	0	0	0	9.21	0	0
	2025	11	19	21	31	10	27	0	0	0	0	0	0	0	9.16	0	0
	2025	11	19	21	41	10	27	0	0	0	0	0	0	0	9.12	0	0
	2025	11	19	21	51	10	27	0	0	0	0	0	0	0	9.07	0	0
	2025	11	19	22	1	10	27	0	0	0	0	0	0	0	9.02	0	0
	2025	11	19	22	11	10	27	0	0	0	0	0	0	0	8.98	0	0
	2025	11	19	22	21	10	27	0	0	0	0	0	0	0	8.94	0	0
	2025	11	19	22	31	10	28	0	0	0	0	0	0	0	8.9	0	0
	2025	11	19	22	41	10	28	0	0	0	0	0	0	0	8.87	0	0
	2025	11	19	22	51	10	27	0	0	0	0	0	0	0	8.84	0	0
	2025	11	19	23	1	10	27	0	0	0	0	0	0	0	8.8	0	0
	2025	11	19	23	11	10	28	0	0	0	0	0	0	0	8.77	0	0
	2025	11	19	23	21	10	28	0	0	0	0	0	0	0	8.75	0	0
	2025	11	19	23	31	10	28	0	0	0	0	0	0	0	8.73	0	0
	2025	11	19	23	41	10	27	0	0	0	0	0	0	0	8.71	0	0
	2025	11	19	23	51	10	28	0	0	0	0	0	0	0	8.7	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	20	0	1	10	27	0	0	0	0	0	0	0	8.68	0	0
2025	11	20	0	11	10	27	0	0	0	0	0	0	0	8.67	0	0
2025	11	20	0	21	10	28	0	0	0	0	0	0	0	8.66	0	0
2025	11	20	0	31	10	28	0	0	0	0	0	0	0	8.65	0	0
2025	11	20	0	41	10	27	0	0	0	0	0	0	0	8.63	0	0
2025	11	20	0	51	10	27	0	0	0	0	0	0	0	8.62	0	0
2025	11	20	1	1	10	27	0	0	0	0	0	0	0	8.61	0	0
2025	11	20	1	11	10	27	0	0	0	0	0	0	0	8.59	0	0
2025	11	20	1	21	10	28	0	0	0	0	0	0	0	8.57	0	0
2025	11	20	1	31	10	27	0	0	0	0	0	0	0	8.56	0	0
2025	11	20	1	41	10	27	0	0	0	0	0	0	0	8.55	0	0
2025	11	20	1	51	10	27	0	0	0	0	0	0	0	8.54	0	0
2025	11	20	2	1	10	28	0	0	0	0	0	0	0	8.53	0	0
2025	11	20	2	11	10	27	0	0	0	0	0	0	0	8.53	0	0
2025	11	20	2	21	10	28	0	0	0	0	0	0	0	8.52	0	0
2025	11	20	2	31	10	28	0	0	0	0	0	0	0	8.52	0	0
2025	11	20	2	41	10	27	0	0	0	0	0	0	0	8.5	0	0
2025	11	20	2	51	10	27	0	0	0	0	0	0	0	8.51	0	0
2025	11	20	3	1	10	27	0	0	0	0	0	0	0	8.5	0	0
2025	11	20	3	11	10	28	0	0	0	0	0	0	0	8.5	0	0
2025	11	20	3	21	10	27	0	0	0	0	0	0	0	8.5	0	0
2025	11	20	3	31	10	27	0	0	0	0	0	0	0	8.5	0	0
2025	11	20	3	41	10	28	0	0	0	0	0	0	0	8.49	0	0
2025	11	20	3	51	10	28	0	0	0	0	0	0	0	8.48	0	0
2025	11	20	4	1	10	28	0	0	0	0	0	0	0	8.48	0	0
2025	11	20	4	11	10	27	0	0	0	0	0	0	0	8.47	0	0
2025	11	20	4	21	10	28	0	0	0	0	0	0	0	8.47	0	0
2025	11	20	4	31	10	28	0	0	0	0	0	0	0	8.46	0	0
2025	11	20	4	41	10	27	0	0	0	0	0	0	0	8.46	0	0
2025	11	20	4	51	10	28	0	0	0	0	0	0	0	8.46	0	0
2025	11	20	5	1	10	27	0	0	0	0	0	0	0	8.45	0	0
2025	11	20	5	11	10	28	0	0	0	0	0	0	0	8.45	0	0
2025	11	20	5	21	10	27	0	0	0	0	0	0	0	8.44	0	0
2025	11	20	5	31	10	28	0	0	0	0	0	0	0	8.44	0	0
2025	11	20	5	41	10	27	0	0	0	0	0	0	0	8.43	0	0
2025	11	20	5	51	10	27	0	0	0	0	0	0	0	8.43	0	0
2025	11	20	6	1	10	27	0	0	0	0	0	0	0	8.43	0	0
2025	11	20	6	11	10	28	0	0	0	0	0	0	0	8.43	0	0
2025	11	20	6	21	10	28	0	0	0	0	0	0	0	8.42	0	0
2025	11	20	6	31	10	28	0	0	0	0	0	0	0	8.41	0	0
2025	11	20	6	41	10	28	0	0	0	0	0	0	0	8.4	0	0
2025	11	20	6	51	10	28	0	0	0	0	0	0	0	8.39	0	0
2025	11	20	7	1	10	27	0	0	0	0	0	0	0	8.38	0	0
2025	11	20	7	11	10	27	0	0	0	0	0	0	0	8.37	0	0
2025	11	20	7	21	10	27	0	0	0	0	0	0	0	8.36	0	0
2025	11	20	7	31	10	28	0	0	0	0	0	0	0	8.36	0	0
2025	11	20	7	41	10	28	0	0	0	0	0	0	0	8.35	0	0
2025	11	20	7	51	10	28	0	0	0	0	0	0	0	8.35	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	11	20	16	1	10	27	0	0	0	0	0	0	0	9.2	0	0
	2025	11	20	16	11	10	28	0	0	0	0	0	0	0	9.21	0	0
	2025	11	20	16	21	10	27	0	0	0	0	0	0	0	9.21	0	0
	2025	11	20	16	31	10	27	0	0	0	0	0	0	0	9.21	0	0
	2025	11	20	16	41	10	27	0	0	0	0	0	0	0	9.22	0	0
	2025	11	20	16	51	10	28	0	0	0	0	0	0	0	9.21	0	0
	2025	11	20	17	1	10	28	0	0	0	0	0	0	0	9.22	0	0
	2025	11	20	17	11	10	27	0	0	0	0	0	0	0	9.22	0	0
	2025	11	20	17	21	10	28	0	0	0	0	0	0	0	9.22	0	0
	2025	11	20	17	31	10	27	0	0	0	0	0	0	0	9.21	0	0
	2025	11	20	17	41	10	27	0	0	0	0	0	0	0	9.21	0	0
	2025	11	20	17	51	10	28	0	0	0	0	0	0	0	9.2	0	0
	2025	11	20	18	1	10	28	0	0	0	0	0	0	0	9.19	0	0
	2025	11	20	18	11	10	27	0	0	0	0	0	0	0	9.19	0	0
	2025	11	20	18	21	10	27	0	0	0	0	0	0	0	9.18	0	0
	2025	11	20	18	31	10	28	0	0	0	0	0	0	0	9.17	0	0
	2025	11	20	18	41	10	28	0	0	0	0	0	0	0	9.16	0	0
	2025	11	20	18	51	10	27	0	0	0	0	0	0	0	9.15	0	0
	2025	11	20	19	1	10	28	0	0	0	0	0	0	0	9.14	0	0
	2025	11	20	19	11	10	27	0	0	0	0	0	0	0	9.13	0	0
	2025	11	20	19	21	10	28	0	0	0	0	0	0	0	9.12	0	0
	2025	11	20	19	31	10	28	0	0	0	0	0	0	0	9.11	0	0
	2025	11	20	19	41	10	28	0	0	0	0	0	0	0	9.1	0	0
	2025	11	20	19	51	10	28	0	0	0	0	0	0	0	9.1	0	0
	2025	11	20	20	1	10	27	0	0	0	0	0	0	0	9.09	0	0
	2025	11	20	20	11	10	28	0	0	0	0	0	0	0	9.07	0	0
	2025	11	20	20	21	10	28	0	0	0	0	0	0	0	9.06	0	0
	2025	11	20	20	31	10	28	0	0	0	0	0	0	0	9.05	0	0
	2025	11	20	20	41	10	28	0	0	0	0	0	0	0	9.04	0	0
	2025	11	20	20	51	10	27	0	0	0	0	0	0	0	9.03	0	0
	2025	11	20	21	1	10	28	0	0	0	0	0	0	0	9.02	0	0
	2025	11	20	21	11	10	28	0	0	0	0	0	0	0	9	0	0
	2025	11	20	21	21	10	27	0	0	0	0	0	0	0	8.99	0	0
	2025	11	20	21	31	10	27	0	0	0	0	0	0	0	8.99	0	0
	2025	11	20	21	41	10	28	0	0	0	0	0	0	0	8.97	0	0
	2025	11	20	21	51	10	28	0	0	0	0	0	0	0	8.97	0	0
	2025	11	20	22	1	10	27	0	0	0	0	0	0	0	8.96	0	0
	2025	11	20	22	11	10	28	0	0	0	0	0	0	0	8.95	0	0
	2025	11	20	22	21	10	27	0	0	0	0	0	0	0	8.94	0	0
	2025	11	20	22	31	10	27	0	0	0	0	0	0	0	8.93	0	0
	2025	11	20	22	41	10	28	0	0	0	0	0	0	0	8.92	0	0
	2025	11	20	22	51	10	28	0	0	0	0	0	0	0	8.91	0	0
	2025	11	20	23	1	10	28	0	0	0	0	0	0	0	8.91	0	0
	2025	11	20	23	11	10	28	0	0	0	0	0	0	0	8.9	0	0
	2025	11	20	23	21	10	27	0	0	0	0	0	0	0	8.89	0	0
	2025	11	20	23	31	10	27	0	0	0	0	0	0	0	8.88	0	0
	2025	11	20	23	41	10	29	0	0	0	0	0	0	0	8.87	0	0
	2025	11	20	23	51	10	28	0	0	0	0	0	0	0	8.86	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	21	0	1	10	28	0	0	0	0	0	0	0	8.86	0	0
2025	11	21	0	11	10	28	0	0	0	0	0	0	0	8.85	0	0
2025	11	21	0	21	10	27	0	0	0	0	0	0	0	8.84	0	0
2025	11	21	0	31	10	28	0	0	0	0	0	0	0	8.83	0	0
2025	11	21	0	41	10	27	0	0	0	0	0	0	0	8.83	0	0
2025	11	21	0	51	10	28	0	0	0	0	0	0	0	8.82	0	0
2025	11	21	1	1	10	28	0	0	0	0	0	0	0	8.81	0	0
2025	11	21	1	11	10	27	0	0	0	0	0	0	0	8.81	0	0
2025	11	21	1	21	10	28	0	0	0	0	0	0	0	8.8	0	0
2025	11	21	1	31	10	28	0	0	0	0	0	0	0	8.8	0	0
2025	11	21	1	41	10	27	0	0	0	0	0	0	0	8.79	0	0
2025	11	21	1	51	10	28	0	0	0	0	0	0	0	8.78	0	0
2025	11	21	2	1	10	27	0	0	0	0	0	0	0	8.78	0	0
2025	11	21	2	11	10	27	0	0	0	0	0	0	0	8.78	0	0
2025	11	21	2	21	10	27	0	0	0	0	0	0	0	8.77	0	0
2025	11	21	2	31	10	28	0	0	0	0	0	0	0	8.76	0	0
2025	11	21	2	41	10	27	0	0	0	0	0	0	0	8.76	0	0
2025	11	21	2	51	10	28	0	0	0	0	0	0	0	8.75	0	0
2025	11	21	3	1	10	27	0	0	0	0	0	0	0	8.74	0	0
2025	11	21	3	11	10	28	0	0	0	0	0	0	0	8.74	0	0
2025	11	21	3	21	10	27	0	0	0	0	0	0	0	8.74	0	0
2025	11	21	3	31	10	28	0	0	0	0	0	0	0	8.73	0	0
2025	11	21	3	41	10	28	0	0	0	0	0	0	0	8.73	0	0
2025	11	21	3	51	10	28	0	0	0	0	0	0	0	8.72	0	0
2025	11	21	4	1	10	27	0	0	0	0	0	0	0	8.72	0	0
2025	11	21	4	11	10	27	0	0	0	0	0	0	0	8.72	0	0
2025	11	21	4	21	10	27	0	0	0	0	0	0	0	8.71	0	0
2025	11	21	4	31	10	28	0	0	0	0	0	0	0	8.71	0	0
2025	11	21	4	41	10	27	0	0	0	0	0	0	0	8.71	0	0
2025	11	21	4	51	10	28	0	0	0	0	0	0	0	8.71	0	0
2025	11	21	5	1	10	27	0	0	0	0	0	0	0	8.71	0	0
2025	11	21	5	11	10	28	0	0	0	0	0	0	0	8.7	0	0
2025	11	21	5	21	10	28	0	0	0	0	0	0	0	8.7	0	0
2025	11	21	5	31	10	28	0	0	0	0	0	0	0	8.7	0	0
2025	11	21	5	41	10	28	0	0	0	0	0	0	0	8.69	0	0
2025	11	21	5	51	10	28	0	0	0	0	0	0	0	8.69	0	0
2025	11	21	6	1	10	28	0	0	0	0	0	0	0	8.69	0	0
2025	11	21	6	11	10	27	0	0	0	0	0	0	0	8.69	0	0
2025	11	21	6	21	10	28	0	0	0	0	0	0	0	8.69	0	0
2025	11	21	6	31	10	27	0	0	0	0	0	0	0	8.68	0	0
2025	11	21	6	41	10	27	0	0	0	0	0	0	0	8.68	0	0
2025	11	21	6	51	10	28	0	0	0	0	0	0	0	8.68	0	0
2025	11	21	7	1	10	27	0	0	0	0	0	0	0	8.68	0	0
2025	11	21	7	11	10	28	0	0	0	0	0	0	0	8.68	0	0
2025	11	21	7	21	10	28	0	0	0	0	0	0	0	8.67	0	0
2025	11	21	7	31	10	27	0	0	0	0	0	0	0	8.66	0	0
2025	11	21	7	41	10	27	0	0	0	0	0	0	0	8.67	0	0
2025	11	21	7	51	10	27	0	0	0	0	0	0	0	8.66	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	21	8	1	10	28	0	0	0	0	0	0	0	8.66	0	0
2025	11	21	8	11	10	28	0	0	0	0	0	0	0	8.65	0	0
2025	11	21	8	21	10	27	0	0	0	0	0	0	0	8.66	0	0
2025	11	21	8	31	10	27	0	0	0	0	0	0	0	8.66	0	0
2025	11	21	8	41	10	28	0	0	0	0	0	0	0	8.66	0	0
2025	11	21	8	51	10	28	0	0	0	0	0	0	0	8.66	0	0
2025	11	21	9	1	10	28	0	0	0	0	0	0	0	8.65	0	0
2025	11	21	9	11	10	27	0	0	0	0	0	0	0	8.65	0	0
2025	11	21	9	21	10	28	0	0	0	0	0	0	0	8.65	0	0
2025	11	21	9	31	10	28	0	0	0	0	0	0	0	8.65	0	0
2025	11	21	9	41	10	27	0	0	0	0	0	0	0	8.65	0	0
2025	11	21	9	51	10	28	0	0	0	0	0	0	0	8.66	0	0
2025	11	21	10	1	10	28	0	0	0	0	0	0	0	8.65	0	0
2025	11	21	10	11	10	27	0	0	0	0	0	0	0	8.65	0	0
2025	11	21	10	21	10	27	0	0	0	0	0	0	0	8.67	0	0
2025	11	21	10	31	10	27	0	0	0	0	0	0	0	8.67	0	0
2025	11	21	10	41	10	27	0	0	0	0	0	0	0	8.67	0	0
2025	11	21	10	51	10	28	0	0	0	0	0	0	0	8.68	0	0
2025	11	21	11	1	10	28	0	0	0	0	0	0	0	8.69	0	0
2025	11	21	11	11	10	27	0	0	0	0	0	0	0	8.7	0	0
2025	11	21	11	21	10	28	0	0	0	0	0	0	0	8.69	0	0
2025	11	21	11	31	10	28	0	0	0	0	0	0	0	8.69	0	0
2025	11	21	11	41	10	28	0	0	0	0	0	0	0	8.71	0	0
2025	11	21	11	51	10	27	0	0	0	0	0	0	0	8.73	0	0
2025	11	21	12	1	10	27	0	0	0	0	0	0	0	8.72	0	0
2025	11	21	12	11	10	27	0	0	0	0	0	0	0	8.72	0	0
2025	11	21	12	21	10	28	0	0	0	0	0	0	0	8.74	0	0
2025	11	21	12	31	10	27	0	0	0	0	0	0	0	8.76	0	0
2025	11	21	12	41	10	28	0	0	0	0	0	0	0	8.75	0	0
2025	11	21	12	51	10	28	0	0	0	0	0	0	0	8.76	0	0
2025	11	21	13	1	10	27	0	0	0	0	0	0	0	8.76	0	0
2025	11	21	13	11	10	27	0	0	0	0	0	0	0	8.75	0	0
2025	11	21	13	21	10	28	0	0	0	0	0	0	0	8.76	0	0
2025	11	21	13	31	10	28	0	0	0	0	0	0	0	8.76	0	0
2025	11	21	13	41	10	28	0	0	0	0	0	0	0	8.77	0	0
2025	11	21	13	51	10	28	0	0	0	0	0	0	0	8.78	0	0
2025	11	21	14	1	10	28	0	0	0	0	0	0	0	8.78	0	0
2025	11	21	14	11	10	29	0	0	0	0	0	0	0	8.78	0	0
2025	11	21	14	21	10	28	0	0	0	0	0	0	0	8.78	0	0
2025	11	21	14	31	10	26	0	0	0	0	0	0	0	8.77	0	0
2025	11	21	14	41	10	27	0	0	0	0	0	0	0	8.76	0	0
2025	11	21	14	51	10	28	0	0	0	0	0	0	0	8.76	0	0
2025	11	21	15	1	10	27	0	0	0	0	0	0	0	8.77	0	0
2025	11	21	15	11	10	28	0	0	0	0	0	0	0	8.77	0	0
2025	11	21	15	21	10	27	0	0	0	0	0	0	0	8.76	0	0
2025	11	21	15	31	10	28	0	0	0	0	0	0	0	8.77	0	0
2025	11	21	15	41	10	27	0	0	0	0	0	0	0	8.77	0	0
2025	11	21	15	51	10	27	0	0	0	0	0	0	0	8.77	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	11	21	16	1	10	28	0	0	0	0	0	0	0	8.77	0	0
	2025	11	21	16	11	10	28	0	0	0	0	0	0	0	8.76	0	0
	2025	11	21	16	21	10	27	0	0	0	0	0	0	0	8.76	0	0
	2025	11	21	16	31	10	27	0	0	0	0	0	0	0	8.76	0	0
	2025	11	21	16	41	10	28	0	0	0	0	0	0	0	8.76	0	0
	2025	11	21	16	51	10	27	0	0	0	0	0	0	0	8.76	0	0
	2025	11	21	17	1	10	27	0	0	0	0	0	0	0	8.76	0	0
	2025	11	21	17	11	10	28	0	0	0	0	0	0	0	8.75	0	0
	2025	11	21	17	21	10	28	0	0	0	0	0	0	0	8.75	0	0
	2025	11	21	17	31	10	28	0	0	0	0	0	0	0	8.75	0	0
	2025	11	21	17	41	10	28	0	0	0	0	0	0	0	8.74	0	0
	2025	11	21	17	51	10	27	0	0	0	0	0	0	0	8.73	0	0
	2025	11	21	18	1	10	27	0	0	0	0	0	0	0	8.73	0	0
	2025	11	21	18	11	10	28	0	0	0	0	0	0	0	8.73	0	0
	2025	11	21	18	21	10	27	0	0	0	0	0	0	0	8.72	0	0
	2025	11	21	18	31	10	28	0	0	0	0	0	0	0	8.72	0	0
	2025	11	21	18	41	10	28	0	0	0	0	0	0	0	8.71	0	0
	2025	11	21	18	51	10	28	0	0	0	0	0	0	0	8.7	0	0
	2025	11	21	19	1	10	28	0	0	0	0	0	0	0	8.7	0	0
	2025	11	21	19	11	10	28	0	0	0	0	0	0	0	8.7	0	0
	2025	11	21	19	21	10	28	0	0	0	0	0	0	0	8.69	0	0
	2025	11	21	19	31	10	28	0	0	0	0	0	0	0	8.69	0	0
	2025	11	21	19	41	10	28	0	0	0	0	0	0	0	8.68	0	0
	2025	11	21	19	51	10	28	0	0	0	0	0	0	0	8.67	0	0
	2025	11	21	20	1	10	28	0	0	0	0	0	0	0	8.66	0	0
	2025	11	21	20	11	10	28	0	0	0	0	0	0	0	8.65	0	0
	2025	11	21	20	21	10	28	0	0	0	0	0	0	0	8.64	0	0
	2025	11	21	20	31	10	28	0	0	0	0	0	0	0	8.63	0	0
	2025	11	21	20	41	10	27	0	0	0	0	0	0	0	8.62	0	0
	2025	11	21	20	51	10	27	0	0	0	0	0	0	0	8.62	0	0
	2025	11	21	21	1	10	28	0	0	0	0	0	0	0	8.61	0	0
	2025	11	21	21	11	10	28	0	0	0	0	0	0	0	8.6	0	0
	2025	11	21	21	21	10	27	0	0	0	0	0	0	0	8.59	0	0
	2025	11	21	21	31	10	27	0	0	0	0	0	0	0	8.59	0	0
	2025	11	21	21	41	10	27	0	0	0	0	0	0	0	8.57	0	0
	2025	11	21	21	51	10	27	0	0	0	0	0	0	0	8.57	0	0
	2025	11	21	22	1	10	28	0	0	0	0	0	0	0	8.56	0	0
	2025	11	21	22	11	10	27	0	0	0	0	0	0	0	8.56	0	0
	2025	11	21	22	21	10	27	0	0	0	0	0	0	0	8.55	0	0
	2025	11	21	22	31	10	27	0	0	0	0	0	0	0	8.54	0	0
	2025	11	21	22	41	10	27	0	0	0	0	0	0	0	8.53	0	0
	2025	11	21	22	51	10	28	0	0	0	0	0	0	0	8.53	0	0
	2025	11	21	23	1	10	28	0	0	0	0	0	0	0	8.53	0	0
	2025	11	21	23	11	10	27	0	0	0	0	0	0	0	8.52	0	0
	2025	11	21	23	21	10	27	0	0	0	0	0	0	0	8.52	0	0
	2025	11	21	23	31	10	28	0	0	0	0	0	0	0	8.51	0	0
	2025	11	21	23	41	10	28	0	0	0	0	0	0	0	8.5	0	0
	2025	11	21	23	51	10	28	0	0	0	0	0	0	0	8.5	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	22	16	1	10	28	0	0	0	0	0	0	0	8.91	0	0
2025	11	22	16	11	10	28	0	0	0	0	0	0	0	8.92	0	0
2025	11	22	16	21	10	27	0	0	0	0	0	0	0	8.94	0	0
2025	11	22	16	31	10	28	0	0	0	0	0	0	0	8.95	0	0
2025	11	22	16	41	10	28	0	0	0	0	0	0	0	8.96	0	0
2025	11	22	16	51	10	28	0	0	0	0	0	0	0	8.97	0	0
2025	11	22	17	1	10	28	0	0	0	0	0	0	0	8.98	0	0
2025	11	22	17	11	10	27	0	0	0	0	0	0	0	8.99	0	0
2025	11	22	17	21	10	27	0	0	0	0	0	0	0	8.99	0	0
2025	11	22	17	31	10	27	0	0	0	0	0	0	0	9	0	0
2025	11	22	17	41	10	28	0	0	0	0	0	0	0	9	0	0
2025	11	22	17	51	10	28	0	0	0	0	0	0	0	9.01	0	0
2025	11	22	18	1	10	27	0	0	0	0	0	0	0	9	0	0
2025	11	22	18	11	10	28	0	0	0	0	0	0	0	9.01	0	0
2025	11	22	18	21	10	27	0	0	0	0	0	0	0	9.01	0	0
2025	11	22	18	31	10	27	0	0	0	0	0	0	0	9.01	0	0
2025	11	22	18	41	10	27	0	0	0	0	0	0	0	9.01	0	0
2025	11	22	18	51	10	27	0	0	0	0	0	0	0	8.99	0	0
2025	11	22	19	1	10	27	0	0	0	0	0	0	0	8.98	0	0
2025	11	22	19	11	10	27	0	0	0	0	0	0	0	8.97	0	0
2025	11	22	19	21	10	27	0	0	0	0	0	0	0	8.96	0	0
2025	11	22	19	31	10	28	0	0	0	0	0	0	0	8.94	0	0
2025	11	22	19	41	10	27	0	0	0	0	0	0	0	8.93	0	0
2025	11	22	19	51	10	27	0	0	0	0	0	0	0	8.91	0	0
2025	11	22	20	1	10	27	0	0	0	0	0	0	0	8.9	0	0
2025	11	22	20	11	10	27	0	0	0	0	0	0	0	8.88	0	0
2025	11	22	20	21	10	27	0	0	0	0	0	0	0	8.87	0	0
2025	11	22	20	31	10	27	0	0	0	0	0	0	0	8.85	0	0
2025	11	22	20	41	10	27	0	0	0	0	0	0	0	8.83	0	0
2025	11	22	20	51	10	28	0	0	0	0	0	0	0	8.81	0	0
2025	11	22	21	1	10	28	0	0	0	0	0	0	0	8.79	0	0
2025	11	22	21	11	10	27	0	0	0	0	0	0	0	8.78	0	0
2025	11	22	21	21	10	28	0	0	0	0	0	0	0	8.76	0	0
2025	11	22	21	31	10	27	0	0	0	0	0	0	0	8.74	0	0
2025	11	22	21	41	10	28	0	0	0	0	0	0	0	8.72	0	0
2025	11	22	21	51	10	27	0	0	0	0	0	0	0	8.7	0	0
2025	11	22	22	1	10	28	0	0	0	0	0	0	0	8.67	0	0
2025	11	22	22	11	10	28	0	0	0	0	0	0	0	8.65	0	0
2025	11	22	22	21	10	28	0	0	0	0	0	0	0	8.63	0	0
2025	11	22	22	31	10	28	0	0	0	0	0	0	0	8.6	0	0
2025	11	22	22	41	10	28	0	0	0	0	0	0	0	8.58	0	0
2025	11	22	22	51	10	27	0	0	0	0	0	0	0	8.56	0	0
2025	11	22	23	1	10	27	0	0	0	0	0	0	0	8.53	0	0
2025	11	22	23	11	10	27	0	0	0	0	0	0	0	8.51	0	0
2025	11	22	23	21	10	28	0	0	0	0	0	0	0	8.48	0	0
2025	11	22	23	31	10	28	0	0	0	0	0	0	0	8.46	0	0
2025	11	22	23	41	10	28	0	0	0	0	0	0	0	8.43	0	0
2025	11	22	23	51	10	27	0	0	0	0	0	0	0	8.41	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	23	0	1	10	27	0	0	0	0	0	0	0	8.38	0	0
2025	11	23	0	11	10	28	0	0	0	0	0	0	0	8.37	0	0
2025	11	23	0	21	10	28	0	0	0	0	0	0	0	8.34	0	0
2025	11	23	0	31	10	28	0	0	0	0	0	0	0	8.31	0	0
2025	11	23	0	41	10	28	0	0	0	0	0	0	0	8.29	0	0
2025	11	23	0	51	10	27	0	0	0	0	0	0	0	8.27	0	0
2025	11	23	1	1	10	28	0	0	0	0	0	0	0	8.24	0	0
2025	11	23	1	11	10	27	0	0	0	0	0	0	0	8.22	0	0
2025	11	23	1	21	10	28	0	0	0	0	0	0	0	8.2	0	0
2025	11	23	1	31	10	28	0	0	0	0	0	0	0	8.18	0	0
2025	11	23	1	41	10	27	0	0	0	0	0	0	0	8.15	0	0
2025	11	23	1	51	10	29	0	0	0	0	0	0	0	8.13	0	0
2025	11	23	2	1	10	28	0	0	0	0	0	0	0	8.1	0	0
2025	11	23	2	11	10	28	0	0	0	0	0	0	0	8.07	0	0
2025	11	23	2	21	10	28	0	0	0	0	0	0	0	8.05	0	0
2025	11	23	2	31	10	27	0	0	0	0	0	0	0	8.02	0	0
2025	11	23	2	41	10	28	0	0	0	0	0	0	0	8	0	0
2025	11	23	2	51	10	28	0	0	0	0	0	0	0	7.97	0	0
2025	11	23	3	1	10	28	0	0	0	0	0	0	0	7.95	0	0
2025	11	23	3	11	10	28	0	0	0	0	0	0	0	7.92	0	0
2025	11	23	3	21	10	28	0	0	0	0	0	0	0	7.89	0	0
2025	11	23	3	31	10	28	0	0	0	0	0	0	0	7.87	0	0
2025	11	23	3	41	10	27	0	0	0	0	0	0	0	7.85	0	0
2025	11	23	3	51	10	28	0	0	0	0	0	0	0	7.82	0	0
2025	11	23	4	1	10	28	0	0	0	0	0	0	0	7.8	0	0
2025	11	23	4	11	10	27	0	0	0	0	0	0	0	7.78	0	0
2025	11	23	4	21	10	28	0	0	0	0	0	0	0	7.76	0	0
2025	11	23	4	31	10	28	0	0	0	0	0	0	0	7.73	0	0
2025	11	23	4	41	10	27	0	0	0	0	0	0	0	7.71	0	0
2025	11	23	4	51	10	27	0	0	0	0	0	0	0	7.69	0	0
2025	11	23	5	1	10	28	0	0	0	0	0	0	0	7.66	0	0
2025	11	23	5	11	10	27	0	0	0	0	0	0	0	7.65	0	0
2025	11	23	5	21	10	27	0	0	0	0	0	0	0	7.63	0	0
2025	11	23	5	31	10	28	0	0	0	0	0	0	0	7.61	0	0
2025	11	23	5	41	10	28	0	0	0	0	0	0	0	7.59	0	0
2025	11	23	5	51	10	28	0	0	0	0	0	0	0	7.57	0	0
2025	11	23	6	1	10	28	0	0	0	0	0	0	0	7.55	0	0
2025	11	23	6	11	10	28	0	0	0	0	0	0	0	7.53	0	0
2025	11	23	6	21	10	28	0	0	0	0	0	0	0	7.52	0	0
2025	11	23	6	31	10	28	0	0	0	0	0	0	0	7.5	0	0
2025	11	23	6	41	10	28	0	0	0	0	0	0	0	7.48	0	0
2025	11	23	6	51	10	28	0	0	0	0	0	0	0	7.46	0	0
2025	11	23	7	1	10	28	0	0	0	0	0	0	0	7.45	0	0
2025	11	23	7	11	10	28	0	0	0	0	0	0	0	7.43	0	0
2025	11	23	7	21	10	28	0	0	0	0	0	0	0	7.41	0	0
2025	11	23	7	31	10	27	0	0	0	0	0	0	0	7.4	0	0
2025	11	23	7	41	10	28	0	0	0	0	0	0	0	7.38	0	0
2025	11	23	7	51	10	28	0	0	0	0	0	0	0	7.36	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	23	8	1	10	28	0	0	0	0	0	0	0	7.34	0	0
2025	11	23	8	11	10	28	0	0	0	0	0	0	0	7.33	0	0
2025	11	23	8	21	10	28	0	0	0	0	0	0	0	7.31	0	0
2025	11	23	8	31	10	28	0	0	0	0	0	0	0	7.3	0	0
2025	11	23	8	41	10	27	0	0	0	0	0	0	0	7.29	0	0
2025	11	23	8	51	10	27	0	0	0	0	0	0	0	7.29	0	0
2025	11	23	9	1	10	27	0	0	0	0	0	0	0	7.3	0	0
2025	11	23	9	11	10	28	0	0	0	0	0	0	0	7.3	0	0
2025	11	23	9	21	10	28	0	0	0	0	0	0	0	7.31	0	0
2025	11	23	9	31	10	28	0	0	0	0	0	0	0	7.31	0	0
2025	11	23	9	41	10	28	0	0	0	0	0	0	0	7.33	0	0
2025	11	23	9	51	10	28	0	0	0	0	0	0	0	7.35	0	0
2025	11	23	10	1	10	28	0	0	0	0	0	0	0	7.36	0	0
2025	11	23	10	11	10	28	0	0	0	0	0	0	0	7.39	0	0
2025	11	23	10	21	10	28	0	0	0	0	0	0	0	7.42	0	0
2025	11	23	10	31	10	28	0	0	0	0	0	0	0	7.45	0	0
2025	11	23	10	41	10	28	0	0	0	0	0	0	0	7.48	0	0
2025	11	23	10	51	10	28	0	0	0	0	0	0	0	7.51	0	0
2025	11	23	11	1	10	28	0	0	0	0	0	0	0	7.56	0	0
2025	11	23	11	11	10	28	0	0	0	0	0	0	0	7.59	0	0
2025	11	23	11	21	10	28	0	0	0	0	0	0	0	7.63	0	0
2025	11	23	11	31	10	29	0	0	0	0	0	0	0	7.68	0	0
2025	11	23	11	41	10	28	0	0	0	0	0	0	0	7.72	0	0
2025	11	23	11	51	10	28	0	0	0	0	0	0	0	7.76	0	0
2025	11	23	12	1	10	28	0	0	0	0	0	0	0	7.81	0	0
2025	11	23	12	11	10	28	0	0	0	0	0	0	0	7.86	0	0
2025	11	23	12	21	10	27	0	0	0	0	0	0	0	7.91	0	0
2025	11	23	12	31	10	28	0	0	0	0	0	0	0	7.96	0	0
2025	11	23	12	41	10	28	0	0	0	0	0	0	0	8.01	0	0
2025	11	23	12	51	10	28	0	0	0	0	0	0	0	8.06	0	0
2025	11	23	13	1	10	28	0	0	0	0	0	0	0	8.11	0	0
2025	11	23	13	11	10	28	0	0	0	0	0	0	0	8.17	0	0
2025	11	23	13	21	10	27	0	0	0	0	0	0	0	8.21	0	0
2025	11	23	13	31	10	28	0	0	0	0	0	0	0	8.25	0	0
2025	11	23	13	41	10	28	0	0	0	0	0	0	0	8.3	0	0
2025	11	23	13	51	10	28	0	0	0	0	0	0	0	8.34	0	0
2025	11	23	14	1	10	28	0	0	0	0	0	0	0	8.38	0	0
2025	11	23	14	11	10	28	0	0	0	0	0	0	0	8.42	0	0
2025	11	23	14	21	10	28	0	0	0	0	0	0	0	8.46	0	0
2025	11	23	14	31	10	28	0	0	0	0	0	0	0	8.49	0	0
2025	11	23	14	41	10	27	0	0	0	0	0	0	0	8.52	0	0
2025	11	23	14	51	10	27	0	0	0	0	0	0	0	8.55	0	0
2025	11	23	15	1	10	28	0	0	0	0	0	0	0	8.58	0	0
2025	11	23	15	11	10	27	0	0	0	0	0	0	0	8.6	0	0
2025	11	23	15	21	10	28	0	0	0	0	0	0	0	8.63	0	0
2025	11	23	15	31	10	28	0	0	0	0	0	0	0	8.65	0	0
2025	11	23	15	41	10	28	0	0	0	0	0	0	0	8.67	0	0
2025	11	23	15	51	10	28	0	0	0	0	0	0	0	8.68	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	11	23	16	1	10	28	0	0	0	0	0	0	0	8.69	0	0
	2025	11	23	16	11	10	28	0	0	0	0	0	0	0	8.7	0	0
	2025	11	23	16	21	10	27	0	0	0	0	0	0	0	8.72	0	0
	2025	11	23	16	31	10	28	0	0	0	0	0	0	0	8.73	0	0
	2025	11	23	16	41	10	27	0	0	0	0	0	0	0	8.74	0	0
	2025	11	23	16	51	10	27	0	0	0	0	0	0	0	8.76	0	0
	2025	11	23	17	1	10	28	0	0	0	0	0	0	0	8.77	0	0
	2025	11	23	17	11	10	28	0	0	0	0	0	0	0	8.78	0	0
	2025	11	23	17	21	10	27	0	0	0	0	0	0	0	8.79	0	0
	2025	11	23	17	31	10	28	0	0	0	0	0	0	0	8.79	0	0
	2025	11	23	17	41	10	28	0	0	0	0	0	0	0	8.79	0	0
	2025	11	23	17	51	10	28	0	0	0	0	0	0	0	8.79	0	0
	2025	11	23	18	1	10	28	0	0	0	0	0	0	0	8.8	0	0
	2025	11	23	18	11	10	28	0	0	0	0	0	0	0	8.8	0	0
	2025	11	23	18	21	10	28	0	0	0	0	0	0	0	8.79	0	0
	2025	11	23	18	31	10	28	0	0	0	0	0	0	0	8.78	0	0
	2025	11	23	18	41	10	28	0	0	0	0	0	0	0	8.77	0	0
	2025	11	23	18	51	10	27	0	0	0	0	0	0	0	8.76	0	0
	2025	11	23	19	1	10	28	0	0	0	0	0	0	0	8.75	0	0
	2025	11	23	19	11	10	28	0	0	0	0	0	0	0	8.73	0	0
	2025	11	23	19	21	10	28	0	0	0	0	0	0	0	8.72	0	0
	2025	11	23	19	31	10	27	0	0	0	0	0	0	0	8.7	0	0
	2025	11	23	19	41	10	28	0	0	0	0	0	0	0	8.67	0	0
	2025	11	23	19	51	10	27	0	0	0	0	0	0	0	8.64	0	0
	2025	11	23	20	1	10	28	0	0	0	0	0	0	0	8.62	0	0
	2025	11	23	20	11	10	28	0	0	0	0	0	0	0	8.59	0	0
	2025	11	23	20	21	10	28	0	0	0	0	0	0	0	8.56	0	0
	2025	11	23	20	31	10	28	0	0	0	0	0	0	0	8.54	0	0
	2025	11	23	20	41	10	27	0	0	0	0	0	0	0	8.5	0	0
	2025	11	23	20	51	10	28	0	0	0	0	0	0	0	8.46	0	0
	2025	11	23	21	1	10	28	0	0	0	0	0	0	0	8.44	0	0
	2025	11	23	21	11	10	28	0	0	0	0	0	0	0	8.4	0	0
	2025	11	23	21	21	10	28	0	0	0	0	0	0	0	8.37	0	0
	2025	11	23	21	31	10	27	0	0	0	0	0	0	0	8.34	0	0
	2025	11	23	21	41	10	28	0	0	0	0	0	0	0	8.31	0	0
	2025	11	23	21	51	10	28	0	0	0	0	0	0	0	8.27	0	0
	2025	11	23	22	1	10	27	0	0	0	0	0	0	0	8.25	0	0
	2025	11	23	22	11	10	27	0	0	0	0	0	0	0	8.21	0	0
	2025	11	23	22	21	10	27	0	0	0	0	0	0	0	8.18	0	0
	2025	11	23	22	31	10	28	0	0	0	0	0	0	0	8.15	0	0
	2025	11	23	22	41	10	28	0	0	0	0	0	0	0	8.12	0	0
	2025	11	23	22	51	10	28	0	0	0	0	0	0	0	8.09	0	0
	2025	11	23	23	1	10	29	0	0	0	0	0	0	0	8.05	0	0
	2025	11	23	23	11	10	27	0	0	0	0	0	0	0	8.02	0	0
	2025	11	23	23	21	10	28	0	0	0	0	0	0	0	7.99	0	0
	2025	11	23	23	31	10	28	0	0	0	0	0	0	0	7.96	0	0
	2025	11	23	23	41	10	28	0	0	0	0	0	0	0	7.92	0	0
	2025	11	23	23	51	10	28	0	0	0	0	0	0	0	7.9	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	24	8	1	10	27	0	0	0	0	0	0	0	6.85	0	0
2025	11	24	8	11	10	28	0	0	0	0	0	0	0	6.85	0	0
2025	11	24	8	21	10	28	0	0	0	0	0	0	0	6.83	0	0
2025	11	24	8	31	10	28	0	0	0	0	0	0	0	6.83	0	0
2025	11	24	8	41	10	28	0	0	0	0	0	0	0	6.83	0	0
2025	11	24	8	51	10	28	0	0	0	0	0	0	0	6.84	0	0
2025	11	24	9	1	10	29	0	0	0	0	0	0	0	6.85	0	0
2025	11	24	9	11	10	28	0	0	0	0	0	0	0	6.86	0	0
2025	11	24	9	21	10	28	0	0	0	0	0	0	0	6.87	0	0
2025	11	24	9	31	10	28	0	0	0	0	0	0	0	6.89	0	0
2025	11	24	9	41	10	28	0	0	0	0	0	0	0	6.91	0	0
2025	11	24	9	51	10	28	0	0	0	0	0	0	0	6.93	0	0
2025	11	24	10	1	10	28	0	0	0	0	0	0	0	6.96	0	0
2025	11	24	10	11	10	28	0	0	0	0	0	0	0	6.99	0	0
2025	11	24	10	21	10	28	0	0	0	0	0	0	0	7.03	0	0
2025	11	24	10	31	10	28	0	0	0	0	0	0	0	7.06	0	0
2025	11	24	10	41	10	28	0	0	0	0	0	0	0	7.1	0	0
2025	11	24	10	51	10	28	0	0	0	0	0	0	0	7.14	0	0
2025	11	24	11	1	10	28	0	0	0	0	0	0	0	7.19	0	0
2025	11	24	11	11	10	28	0	0	0	0	0	0	0	7.23	0	0
2025	11	24	11	21	10	27	0	0	0	0	0	0	0	7.28	0	0
2025	11	24	11	31	10	28	0	0	0	0	0	0	0	7.33	0	0
2025	11	24	11	41	10	28	0	0	0	0	0	0	0	7.38	0	0
2025	11	24	11	51	10	28	0	0	0	0	0	0	0	7.44	0	0
2025	11	24	12	1	10	28	0	0	0	0	0	0	0	7.5	0	0
2025	11	24	12	11	10	28	0	0	0	0	0	0	0	7.55	0	0
2025	11	24	12	21	10	27	0	0	0	0	0	0	0	7.6	0	0
2025	11	24	12	31	10	28	0	0	0	0	0	0	0	7.66	0	0
2025	11	24	12	41	10	28	0	0	0	0	0	0	0	7.72	0	0
2025	11	24	12	51	10	27	0	0	0	0	0	0	0	7.78	0	0
2025	11	24	13	1	10	28	0	0	0	0	0	0	0	7.83	0	0
2025	11	24	13	11	10	28	0	0	0	0	0	0	0	7.88	0	0
2025	11	24	13	21	10	28	0	0	0	0	0	0	0	7.93	0	0
2025	11	24	13	31	10	28	0	0	0	0	0	0	0	7.99	0	0
2025	11	24	13	41	10	27	0	0	0	0	0	0	0	8.03	0	0
2025	11	24	13	51	10	28	0	0	0	0	0	0	0	8.08	0	0
2025	11	24	14	1	10	28	0	0	0	0	0	0	0	8.13	0	0
2025	11	24	14	11	10	28	0	0	0	0	0	0	0	8.17	0	0
2025	11	24	14	21	10	28	0	0	0	0	0	0	0	8.21	0	0
2025	11	24	14	31	10	28	0	0	0	0	0	0	0	8.25	0	0
2025	11	24	14	41	10	27	0	0	0	0	0	0	0	8.29	0	0
2025	11	24	14	51	10	28	0	0	0	0	0	0	0	8.32	0	0
2025	11	24	15	1	10	28	0	0	0	0	0	0	0	8.35	0	0
2025	11	24	15	11	10	28	0	0	0	0	0	0	0	8.38	0	0
2025	11	24	15	21	10	28	0	0	0	0	0	0	0	8.41	0	0
2025	11	24	15	31	10	27	0	0	0	0	0	0	0	8.42	0	0
2025	11	24	15	41	10	28	0	0	0	0	0	0	0	8.44	0	0
2025	11	24	15	51	10	27	0	0	0	0	0	0	0	8.46	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	11	24	16	1	10	27	0	0	0	0	0	0	0	8.46	0	0
	2025	11	24	16	11	10	28	0	0	0	0	0	0	0	8.47	0	0
	2025	11	24	16	21	10	28	0	0	0	0	0	0	0	8.48	0	0
	2025	11	24	16	31	10	28	0	0	0	0	0	0	0	8.49	0	0
	2025	11	24	16	41	10	29	0	0	0	0	0	0	0	8.5	0	0
	2025	11	24	16	51	10	28	0	0	0	0	0	0	0	8.51	0	0
	2025	11	24	17	1	10	28	0	0	0	0	0	0	0	8.52	0	0
	2025	11	24	17	11	10	27	0	0	0	0	0	0	0	8.53	0	0
	2025	11	24	17	21	10	28	0	0	0	0	0	0	0	8.53	0	0
	2025	11	24	17	31	10	27	0	0	0	0	0	0	0	8.52	0	0
	2025	11	24	17	41	10	28	0	0	0	0	0	0	0	8.52	0	0
	2025	11	24	17	51	10	28	0	0	0	0	0	0	0	8.51	0	0
	2025	11	24	18	1	10	28	0	0	0	0	0	0	0	8.51	0	0
	2025	11	24	18	11	10	28	0	0	0	0	0	0	0	8.5	0	0
	2025	11	24	18	21	10	27	0	0	0	0	0	0	0	8.48	0	0
	2025	11	24	18	31	10	28	0	0	0	0	0	0	0	8.47	0	0
	2025	11	24	18	41	10	27	0	0	0	0	0	0	0	8.45	0	0
	2025	11	24	18	51	10	27	0	0	0	0	0	0	0	8.43	0	0
	2025	11	24	19	1	10	28	0	0	0	0	0	0	0	8.41	0	0
	2025	11	24	19	11	10	27	0	0	0	0	0	0	0	8.39	0	0
	2025	11	24	19	21	10	28	0	0	0	0	0	0	0	8.36	0	0
	2025	11	24	19	31	10	28	0	0	0	0	0	0	0	8.33	0	0
	2025	11	24	19	41	10	28	0	0	0	0	0	0	0	8.3	0	0
	2025	11	24	19	51	10	27	0	0	0	0	0	0	0	8.27	0	0
	2025	11	24	20	1	10	27	0	0	0	0	0	0	0	8.24	0	0
	2025	11	24	20	11	10	28	0	0	0	0	0	0	0	8.2	0	0
	2025	11	24	20	21	10	27	0	0	0	0	0	0	0	8.17	0	0
	2025	11	24	20	31	10	28	0	0	0	0	0	0	0	8.14	0	0
	2025	11	24	20	41	10	27	0	0	0	0	0	0	0	8.1	0	0
	2025	11	24	20	51	10	28	0	0	0	0	0	0	0	8.07	0	0
	2025	11	24	21	1	10	28	0	0	0	0	0	0	0	8.03	0	0
	2025	11	24	21	11	10	27	0	0	0	0	0	0	0	7.99	0	0
	2025	11	24	21	21	10	27	0	0	0	0	0	0	0	7.96	0	0
	2025	11	24	21	31	10	27	0	0	0	0	0	0	0	7.92	0	0
	2025	11	24	21	41	10	28	0	0	0	0	0	0	0	7.89	0	0
	2025	11	24	21	51	10	28	0	0	0	0	0	0	0	7.86	0	0
	2025	11	24	22	1	10	27	0	0	0	0	0	0	0	7.82	0	0
	2025	11	24	22	11	10	27	0	0	0	0	0	0	0	7.78	0	0
	2025	11	24	22	21	10	27	0	0	0	0	0	0	0	7.75	0	0
	2025	11	24	22	31	10	27	0	0	0	0	0	0	0	7.72	0	0
	2025	11	24	22	41	10	28	0	0	0	0	0	0	0	7.68	0	0
	2025	11	24	22	51	10	28	0	0	0	0	0	0	0	7.65	0	0
	2025	11	24	23	1	10	27	0	0	0	0	0	0	0	7.61	0	0
	2025	11	24	23	11	10	28	0	0	0	0	0	0	0	7.58	0	0
	2025	11	24	23	21	10	28	0	0	0	0	0	0	0	7.55	0	0
	2025	11	24	23	31	10	28	0	0	0	0	0	0	0	7.51	0	0
	2025	11	24	23	41	10	28	0	0	0	0	0	0	0	7.48	0	0
	2025	11	24	23	51	10	28	0	0	0	0	0	0	0	7.45	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	25	0	1	10	28	0	0	0	0	0	0	0	7.42	0	0
2025	11	25	0	11	10	28	0	0	0	0	0	0	0	7.38	0	0
2025	11	25	0	21	10	27	0	0	0	0	0	0	0	7.35	0	0
2025	11	25	0	31	10	28	0	0	0	0	0	0	0	7.32	0	0
2025	11	25	0	41	10	28	0	0	0	0	0	0	0	7.29	0	0
2025	11	25	0	51	10	28	0	0	0	0	0	0	0	7.26	0	0
2025	11	25	1	1	10	28	0	0	0	0	0	0	0	7.23	0	0
2025	11	25	1	11	10	28	0	0	0	0	0	0	0	7.2	0	0
2025	11	25	1	21	10	28	0	0	0	0	0	0	0	7.18	0	0
2025	11	25	1	31	10	28	0	0	0	0	0	0	0	7.14	0	0
2025	11	25	1	41	10	28	0	0	0	0	0	0	0	7.12	0	0
2025	11	25	1	51	10	28	0	0	0	0	0	0	0	7.09	0	0
2025	11	25	2	1	10	28	0	0	0	0	0	0	0	7.07	0	0
2025	11	25	2	11	10	27	0	0	0	0	0	0	0	7.04	0	0
2025	11	25	2	21	10	28	0	0	0	0	0	0	0	7.02	0	0
2025	11	25	2	31	10	28	0	0	0	0	0	0	0	7	0	0
2025	11	25	2	41	10	28	0	0	0	0	0	0	0	6.97	0	0
2025	11	25	2	51	10	28	0	0	0	0	0	0	0	6.95	0	0
2025	11	25	3	1	10	28	0	0	0	0	0	0	0	6.92	0	0
2025	11	25	3	11	10	29	0	0	0	0	0	0	0	6.9	0	0
2025	11	25	3	21	10	27	0	0	0	0	0	0	0	6.88	0	0
2025	11	25	3	31	10	27	0	0	0	0	0	0	0	6.86	0	0
2025	11	25	3	41	10	28	0	0	0	0	0	0	0	6.83	0	0
2025	11	25	3	51	10	28	0	0	0	0	0	0	0	6.82	0	0
2025	11	25	4	1	10	28	0	0	0	0	0	0	0	6.8	0	0
2025	11	25	4	11	10	28	0	0	0	0	0	0	0	6.78	0	0
2025	11	25	4	21	10	28	0	0	0	0	0	0	0	6.76	0	0
2025	11	25	4	31	10	28	0	0	0	0	0	0	0	6.75	0	0
2025	11	25	4	41	10	28	0	0	0	0	0	0	0	6.73	0	0
2025	11	25	4	51	10	28	0	0	0	0	0	0	0	6.72	0	0
2025	11	25	5	1	10	28	0	0	0	0	0	0	0	6.7	0	0
2025	11	25	5	11	10	28	0	0	0	0	0	0	0	6.69	0	0
2025	11	25	5	21	10	28	0	0	0	0	0	0	0	6.68	0	0
2025	11	25	5	31	10	28	0	0	0	0	0	0	0	6.67	0	0
2025	11	25	5	41	10	28	0	0	0	0	0	0	0	6.66	0	0
2025	11	25	5	51	10	28	0	0	0	0	0	0	0	6.65	0	0
2025	11	25	6	1	10	28	0	0	0	0	0	0	0	6.64	0	0
2025	11	25	6	11	10	28	0	0	0	0	0	0	0	6.62	0	0
2025	11	25	6	21	10	28	0	0	0	0	0	0	0	6.62	0	0
2025	11	25	6	31	10	28	0	0	0	0	0	0	0	6.61	0	0
2025	11	25	6	41	10	29	0	0	0	0	0	0	0	6.59	0	0
2025	11	25	6	51	10	28	0	0	0	0	0	0	0	6.59	0	0
2025	11	25	7	1	10	28	0	0	0	0	0	0	0	6.58	0	0
2025	11	25	7	11	10	27	0	0	0	0	0	0	0	6.58	0	0
2025	11	25	7	21	10	28	0	0	0	0	0	0	0	6.57	0	0
2025	11	25	7	31	10	28	0	0	0	0	0	0	0	6.56	0	0
2025	11	25	7	41	10	28	0	0	0	0	0	0	0	6.55	0	0
2025	11	25	7	51	10	28	0	0	0	0	0	0	0	6.54	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	26	0	1	10	28	0	0	0	0	0	0	0	7.2	0	0
2025	11	26	0	11	10	28	0	0	0	0	0	0	0	7.17	0	0
2025	11	26	0	21	10	28	0	0	0	0	0	0	0	7.14	0	0
2025	11	26	0	31	10	28	0	0	0	0	0	0	0	7.12	0	0
2025	11	26	0	41	10	27	0	0	0	0	0	0	0	7.09	0	0
2025	11	26	0	51	10	28	0	0	0	0	0	0	0	7.06	0	0
2025	11	26	1	1	10	28	0	0	0	0	0	0	0	7.04	0	0
2025	11	26	1	11	10	27	0	0	0	0	0	0	0	7	0	0
2025	11	26	1	21	10	28	0	0	0	0	0	0	0	6.98	0	0
2025	11	26	1	31	10	28	0	0	0	0	0	0	0	6.94	0	0
2025	11	26	1	41	10	28	0	0	0	0	0	0	0	6.92	0	0
2025	11	26	1	51	10	28	0	0	0	0	0	0	0	6.9	0	0
2025	11	26	2	1	10	28	0	0	0	0	0	0	0	6.88	0	0
2025	11	26	2	11	10	28	0	0	0	0	0	0	0	6.85	0	0
2025	11	26	2	21	10	28	0	0	0	0	0	0	0	6.83	0	0
2025	11	26	2	31	10	28	0	0	0	0	0	0	0	6.81	0	0
2025	11	26	2	41	10	28	0	0	0	0	0	0	0	6.78	0	0
2025	11	26	2	51	10	28	0	0	0	0	0	0	0	6.76	0	0
2025	11	26	3	1	10	27	0	0	0	0	0	0	0	6.74	0	0
2025	11	26	3	11	10	27	0	0	0	0	0	0	0	6.72	0	0
2025	11	26	3	21	10	27	0	0	0	0	0	0	0	6.7	0	0
2025	11	26	3	31	10	28	0	0	0	0	0	0	0	6.68	0	0
2025	11	26	3	41	10	28	0	0	0	0	0	0	0	6.67	0	0
2025	11	26	3	51	10	28	0	0	0	0	0	0	0	6.65	0	0
2025	11	26	4	1	10	28	0	0	0	0	0	0	0	6.63	0	0
2025	11	26	4	11	10	28	0	0	0	0	0	0	0	6.61	0	0
2025	11	26	4	21	10	28	0	0	0	0	0	0	0	6.6	0	0
2025	11	26	4	31	10	28	0	0	0	0	0	0	0	6.59	0	0
2025	11	26	4	41	10	28	0	0	0	0	0	0	0	6.57	0	0
2025	11	26	4	51	10	28	0	0	0	0	0	0	0	6.56	0	0
2025	11	26	5	1	10	28	0	0	0	0	0	0	0	6.55	0	0
2025	11	26	5	11	10	28	0	0	0	0	0	0	0	6.54	0	0
2025	11	26	5	21	10	28	0	0	0	0	0	0	0	6.53	0	0
2025	11	26	5	31	10	28	0	0	0	0	0	0	0	6.52	0	0
2025	11	26	5	41	10	28	0	0	0	0	0	0	0	6.51	0	0
2025	11	26	5	51	10	28	0	0	0	0	0	0	0	6.5	0	0
2025	11	26	6	1	10	28	0	0	0	0	0	0	0	6.5	0	0
2025	11	26	6	11	10	28	0	0	0	0	0	0	0	6.49	0	0
2025	11	26	6	21	10	28	0	0	0	0	0	0	0	6.48	0	0
2025	11	26	6	31	10	29	0	0	0	0	0	0	0	6.48	0	0
2025	11	26	6	41	10	28	0	0	0	0	0	0	0	6.47	0	0
2025	11	26	6	51	10	28	0	0	0	0	0	0	0	6.46	0	0
2025	11	26	7	1	10	28	0	0	0	0	0	0	0	6.45	0	0
2025	11	26	7	11	10	28	0	0	0	0	0	0	0	6.44	0	0
2025	11	26	7	21	10	28	0	0	0	0	0	0	0	6.44	0	0
2025	11	26	7	31	10	28	0	0	0	0	0	0	0	6.44	0	0
2025	11	26	7	41	10	29	0	0	0	0	0	0	0	6.43	0	0
2025	11	26	7	51	10	28	0	0	0	0	0	0	0	6.42	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	26	8	1	10	27	0	0	0	0	0	0	0	6.42	0	0
2025	11	26	8	11	10	28	0	0	0	0	0	0	0	6.42	0	0
2025	11	26	8	21	10	28	0	0	0	0	0	0	0	6.41	0	0
2025	11	26	8	31	10	28	0	0	0	0	0	0	0	6.41	0	0
2025	11	26	8	41	10	28	0	0	0	0	0	0	0	6.41	0	0
2025	11	26	8	51	10	28	0	0	0	0	0	0	0	6.42	0	0
2025	11	26	9	1	10	28	0	0	0	0	0	0	0	6.43	0	0
2025	11	26	9	11	10	28	0	0	0	0	0	0	0	6.44	0	0
2025	11	26	9	21	10	28	0	0	0	0	0	0	0	6.45	0	0
2025	11	26	9	31	10	28	0	0	0	0	0	0	0	6.48	0	0
2025	11	26	9	41	10	28	0	0	0	0	0	0	0	6.5	0	0
2025	11	26	9	51	10	28	0	0	0	0	0	0	0	6.53	0	0
2025	11	26	10	1	10	27	0	0	0	0	0	0	0	6.56	0	0
2025	11	26	10	11	10	28	0	0	0	0	0	0	0	6.59	0	0
2025	11	26	10	21	10	27	0	0	0	0	0	0	0	6.63	0	0
2025	11	26	10	31	10	28	0	0	0	0	0	0	0	6.68	0	0
2025	11	26	10	41	10	27	0	0	0	0	0	0	0	6.72	0	0
2025	11	26	10	51	10	28	0	0	0	0	0	0	0	6.76	0	0
2025	11	26	11	1	10	28	0	0	0	0	0	0	0	6.81	0	0
2025	11	26	11	11	10	28	0	0	0	0	0	0	0	6.86	0	0
2025	11	26	11	21	10	29	0	0	0	0	0	0	0	6.91	0	0
2025	11	26	11	31	10	27	0	0	0	0	0	0	0	6.96	0	0
2025	11	26	11	41	10	28	0	0	0	0	0	0	0	7.02	0	0
2025	11	26	11	51	10	28	0	0	0	0	0	0	0	7.07	0	0
2025	11	26	12	1	10	28	0	0	0	0	0	0	0	7.12	0	0
2025	11	26	12	11	10	28	0	0	0	0	0	0	0	7.18	0	0
2025	11	26	12	21	10	28	0	0	0	0	0	0	0	7.25	0	0
2025	11	26	12	31	10	28	0	0	0	0	0	0	0	7.31	0	0
2025	11	26	12	41	10	28	0	0	0	0	0	0	0	7.36	0	0
2025	11	26	12	51	10	28	0	0	0	0	0	0	0	7.42	0	0
2025	11	26	13	1	10	28	0	0	0	0	0	0	0	7.48	0	0
2025	11	26	13	11	10	28	0	0	0	0	0	0	0	7.53	0	0
2025	11	26	13	21	10	28	0	0	0	0	0	0	0	7.59	0	0
2025	11	26	13	31	10	28	0	0	0	0	0	0	0	7.64	0	0
2025	11	26	13	41	10	28	0	0	0	0	0	0	0	7.68	0	0
2025	11	26	13	51	10	27	0	0	0	0	0	0	0	7.73	0	0
2025	11	26	14	1	10	28	0	0	0	0	0	0	0	7.78	0	0
2025	11	26	14	11	10	27	0	0	0	0	0	0	0	7.82	0	0
2025	11	26	14	21	10	28	0	0	0	0	0	0	0	7.86	0	0
2025	11	26	14	31	10	28	0	0	0	0	0	0	0	7.9	0	0
2025	11	26	14	41	10	28	0	0	0	0	0	0	0	7.95	0	0
2025	11	26	14	51	10	28	0	0	0	0	0	0	0	7.97	0	0
2025	11	26	15	1	10	28	0	0	0	0	0	0	0	8	0	0
2025	11	26	15	11	10	28	0	0	0	0	0	0	0	8.04	0	0
2025	11	26	15	21	10	28	0	0	0	0	0	0	0	8.06	0	0
2025	11	26	15	31	10	28	0	0	0	0	0	0	0	8.09	0	0
2025	11	26	15	41	10	28	0	0	0	0	0	0	0	8.1	0	0
2025	11	26	15	51	10	28	0	0	0	0	0	0	0	8.12	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	26	16	1	10	28	0	0	0	0	0	0	0	8.13	0	0
2025	11	26	16	11	10	28	0	0	0	0	0	0	0	8.14	0	0
2025	11	26	16	21	10	27	0	0	0	0	0	0	0	8.16	0	0
2025	11	26	16	31	10	28	0	0	0	0	0	0	0	8.17	0	0
2025	11	26	16	41	10	28	0	0	0	0	0	0	0	8.18	0	0
2025	11	26	16	51	10	28	0	0	0	0	0	0	0	8.19	0	0
2025	11	26	17	1	10	28	0	0	0	0	0	0	0	8.2	0	0
2025	11	26	17	11	10	27	0	0	0	0	0	0	0	8.2	0	0
2025	11	26	17	21	10	27	0	0	0	0	0	0	0	8.2	0	0
2025	11	26	17	31	10	28	0	0	0	0	0	0	0	8.2	0	0
2025	11	26	17	41	10	27	0	0	0	0	0	0	0	8.2	0	0
2025	11	26	17	51	10	27	0	0	0	0	0	0	0	8.19	0	0
2025	11	26	18	1	10	27	0	0	0	0	0	0	0	8.19	0	0
2025	11	26	18	11	10	28	0	0	0	0	0	0	0	8.17	0	0
2025	11	26	18	21	10	28	0	0	0	0	0	0	0	8.16	0	0
2025	11	26	18	31	10	28	0	0	0	0	0	0	0	8.15	0	0
2025	11	26	18	41	10	27	0	0	0	0	0	0	0	8.12	0	0
2025	11	26	18	51	10	27	0	0	0	0	0	0	0	8.1	0	0
2025	11	26	19	1	10	27	0	0	0	0	0	0	0	8.08	0	0
2025	11	26	19	11	10	27	0	0	0	0	0	0	0	8.05	0	0
2025	11	26	19	21	10	28	0	0	0	0	0	0	0	8.03	0	0
2025	11	26	19	31	10	28	0	0	0	0	0	0	0	8	0	0
2025	11	26	19	41	10	28	0	0	0	0	0	0	0	7.97	0	0
2025	11	26	19	51	10	28	0	0	0	0	0	0	0	7.94	0	0
2025	11	26	20	1	10	28	0	0	0	0	0	0	0	7.9	0	0
2025	11	26	20	11	10	27	0	0	0	0	0	0	0	7.87	0	0
2025	11	26	20	21	10	28	0	0	0	0	0	0	0	7.84	0	0
2025	11	26	20	31	10	29	0	0	0	0	0	0	0	7.8	0	0
2025	11	26	20	41	10	28	0	0	0	0	0	0	0	7.77	0	0
2025	11	26	20	51	10	28	0	0	0	0	0	0	0	7.73	0	0
2025	11	26	21	1	10	28	0	0	0	0	0	0	0	7.7	0	0
2025	11	26	21	11	10	28	0	0	0	0	0	0	0	7.66	0	0
2025	11	26	21	21	10	27	0	0	0	0	0	0	0	7.63	0	0
2025	11	26	21	31	10	28	0	0	0	0	0	0	0	7.6	0	0
2025	11	26	21	41	10	27	0	0	0	0	0	0	0	7.57	0	0
2025	11	26	21	51	10	27	0	0	0	0	0	0	0	7.53	0	0
2025	11	26	22	1	10	28	0	0	0	0	0	0	0	7.5	0	0
2025	11	26	22	11	10	28	0	0	0	0	0	0	0	7.47	0	0
2025	11	26	22	21	10	28	0	0	0	0	0	0	0	7.44	0	0
2025	11	26	22	31	10	28	0	0	0	0	0	0	0	7.41	0	0
2025	11	26	22	41	10	28	0	0	0	0	0	0	0	7.38	0	0
2025	11	26	22	51	10	28	0	0	0	0	0	0	0	7.35	0	0
2025	11	26	23	1	10	28	0	0	0	0	0	0	0	7.32	0	0
2025	11	26	23	11	10	28	0	0	0	0	0	0	0	7.29	0	0
2025	11	26	23	21	10	28	0	0	0	0	0	0	0	7.27	0	0
2025	11	26	23	31	10	28	0	0	0	0	0	0	0	7.23	0	0
2025	11	26	23	41	10	28	0	0	0	0	0	0	0	7.2	0	0
2025	11	26	23	51	10	28	0	0	0	0	0	0	0	7.17	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	27	0	1	10	28	0	0	0	0	0	0	0	7.14	0	0
2025	11	27	0	11	10	28	0	0	0	0	0	0	0	7.12	0	0
2025	11	27	0	21	10	27	0	0	0	0	0	0	0	7.09	0	0
2025	11	27	0	31	10	28	0	0	0	0	0	0	0	7.07	0	0
2025	11	27	0	41	10	28	0	0	0	0	0	0	0	7.05	0	0
2025	11	27	0	51	10	28	0	0	0	0	0	0	0	7.02	0	0
2025	11	27	1	1	10	28	0	0	0	0	0	0	0	6.99	0	0
2025	11	27	1	11	10	28	0	0	0	0	0	0	0	6.97	0	0
2025	11	27	1	21	10	28	0	0	0	0	0	0	0	6.95	0	0
2025	11	27	1	31	10	28	0	0	0	0	0	0	0	6.92	0	0
2025	11	27	1	41	10	28	0	0	0	0	0	0	0	6.9	0	0
2025	11	27	1	51	10	28	0	0	0	0	0	0	0	6.87	0	0
2025	11	27	2	1	10	28	0	0	0	0	0	0	0	6.85	0	0
2025	11	27	2	11	10	28	0	0	0	0	0	0	0	6.82	0	0
2025	11	27	2	21	10	28	0	0	0	0	0	0	0	6.8	0	0
2025	11	27	2	31	10	28	0	0	0	0	0	0	0	6.78	0	0
2025	11	27	2	41	10	28	0	0	0	0	0	0	0	6.76	0	0
2025	11	27	2	51	10	28	0	0	0	0	0	0	0	6.74	0	0
2025	11	27	3	1	10	28	0	0	0	0	0	0	0	6.72	0	0
2025	11	27	3	11	10	28	0	0	0	0	0	0	0	6.7	0	0
2025	11	27	3	21	10	28	0	0	0	0	0	0	0	6.68	0	0
2025	11	27	3	31	10	28	0	0	0	0	0	0	0	6.66	0	0
2025	11	27	3	41	10	28	0	0	0	0	0	0	0	6.64	0	0
2025	11	27	3	51	10	28	0	0	0	0	0	0	0	6.62	0	0
2025	11	27	4	1	10	28	0	0	0	0	0	0	0	6.6	0	0
2025	11	27	4	11	10	27	0	0	0	0	0	0	0	6.58	0	0
2025	11	27	4	21	10	27	0	0	0	0	0	0	0	6.57	0	0
2025	11	27	4	31	10	28	0	0	0	0	0	0	0	6.55	0	0
2025	11	27	4	41	10	28	0	0	0	0	0	0	0	6.53	0	0
2025	11	27	4	51	10	28	0	0	0	0	0	0	0	6.52	0	0
2025	11	27	5	1	10	29	0	0	0	0	0	0	0	6.51	0	0
2025	11	27	5	11	10	28	0	0	0	0	0	0	0	6.5	0	0
2025	11	27	5	21	10	28	0	0	0	0	0	0	0	6.49	0	0
2025	11	27	5	31	10	28	0	0	0	0	0	0	0	6.48	0	0
2025	11	27	5	41	10	27	0	0	0	0	0	0	0	6.47	0	0
2025	11	27	5	51	10	28	0	0	0	0	0	0	0	6.46	0	0
2025	11	27	6	1	10	28	0	0	0	0	0	0	0	6.44	0	0
2025	11	27	6	11	10	28	0	0	0	0	0	0	0	6.44	0	0
2025	11	27	6	21	10	28	0	0	0	0	0	0	0	6.43	0	0
2025	11	27	6	31	10	28	0	0	0	0	0	0	0	6.41	0	0
2025	11	27	6	41	10	27	0	0	0	0	0	0	0	6.4	0	0
2025	11	27	6	51	10	28	0	0	0	0	0	0	0	6.4	0	0
2025	11	27	7	1	10	28	0	0	0	0	0	0	0	6.39	0	0
2025	11	27	7	11	10	29	0	0	0	0	0	0	0	6.38	0	0
2025	11	27	7	21	10	28	0	0	0	0	0	0	0	6.37	0	0
2025	11	27	7	31	10	28	0	0	0	0	0	0	0	6.37	0	0
2025	11	27	7	41	10	27	0	0	0	0	0	0	0	6.36	0	0
2025	11	27	7	51	10	28	0	0	0	0	0	0	0	6.36	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	27	8	1	10	28	0	0	0	0	0	0	0	6.36	0	0
2025	11	27	8	11	10	28	0	0	0	0	0	0	0	6.35	0	0
2025	11	27	8	21	10	28	0	0	0	0	0	0	0	6.35	0	0
2025	11	27	8	31	10	27	0	0	0	0	0	0	0	6.36	0	0
2025	11	27	8	41	10	28	0	0	0	0	0	0	0	6.36	0	0
2025	11	27	8	51	10	28	0	0	0	0	0	0	0	6.38	0	0
2025	11	27	9	1	10	28	0	0	0	0	0	0	0	6.39	0	0
2025	11	27	9	11	10	28	0	0	0	0	0	0	0	6.4	0	0
2025	11	27	9	21	10	28	0	0	0	0	0	0	0	6.44	0	0
2025	11	27	9	31	10	28	0	0	0	0	0	0	0	6.46	0	0
2025	11	27	9	41	10	28	0	0	0	0	0	0	0	6.47	0	0
2025	11	27	9	51	10	28	0	0	0	0	0	0	0	6.51	0	0
2025	11	27	10	1	10	28	0	0	0	0	0	0	0	6.54	0	0
2025	11	27	10	11	10	28	0	0	0	0	0	0	0	6.57	0	0
2025	11	27	10	21	10	27	0	0	0	0	0	0	0	6.59	0	0
2025	11	27	10	31	10	28	0	0	0	0	0	0	0	6.62	0	0
2025	11	27	10	41	10	28	0	0	0	0	0	0	0	6.65	0	0
2025	11	27	10	51	10	28	0	0	0	0	0	0	0	6.7	0	0
2025	11	27	11	1	10	28	0	0	0	0	0	0	0	6.73	0	0
2025	11	27	11	11	10	28	0	0	0	0	0	0	0	6.79	0	0
2025	11	27	11	21	10	28	0	0	0	0	0	0	0	6.83	0	0
2025	11	27	11	31	10	28	0	0	0	0	0	0	0	6.88	0	0
2025	11	27	11	41	10	28	0	0	0	0	0	0	0	6.91	0	0
2025	11	27	11	51	10	28	0	0	0	0	0	0	0	6.94	0	0
2025	11	27	12	1	10	28	0	0	0	0	0	0	0	6.99	0	0
2025	11	27	12	11	10	28	0	0	0	0	0	0	0	7.05	0	0
2025	11	27	12	21	10	28	0	0	0	0	0	0	0	7.09	0	0
2025	11	27	12	31	10	28	0	0	0	0	0	0	0	7.12	0	0
2025	11	27	12	41	10	28	0	0	0	0	0	0	0	7.19	0	0
2025	11	27	12	51	10	28	0	0	0	0	0	0	0	7.26	0	0
2025	11	27	13	1	10	28	0	0	0	0	0	0	0	7.31	0	0
2025	11	27	13	11	10	28	0	0	0	0	0	0	0	7.34	0	0
2025	11	27	13	21	10	28	0	0	0	0	0	0	0	7.4	0	0
2025	11	27	13	31	10	28	0	0	0	0	0	0	0	7.48	0	0
2025	11	27	13	41	10	28	0	0	0	0	0	0	0	7.55	0	0
2025	11	27	13	51	10	28	0	0	0	0	0	0	0	7.57	0	0
2025	11	27	14	1	10	28	0	0	0	0	0	0	0	7.58	0	0
2025	11	27	14	11	10	28	0	0	0	0	0	0	0	7.65	0	0
2025	11	27	14	21	10	29	0	0	0	0	0	0	0	7.68	0	0
2025	11	27	14	31	10	28	0	0	0	0	0	0	0	7.71	0	0
2025	11	27	14	41	10	27	0	0	0	0	0	0	0	7.76	0	0
2025	11	27	14	51	10	27	0	0	0	0	0	0	0	7.81	0	0
2025	11	27	15	1	10	27	0	0	0	0	0	0	0	7.83	0	0
2025	11	27	15	11	10	28	0	0	0	0	0	0	0	7.86	0	0
2025	11	27	15	21	10	28	0	0	0	0	0	0	0	7.88	0	0
2025	11	27	15	31	10	28	0	0	0	0	0	0	0	7.9	0	0
2025	11	27	15	41	10	27	0	0	0	0	0	0	0	7.92	0	0
2025	11	27	15	51	10	29	0	0	0	0	0	0	0	7.94	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	27	16	1	10	28	0	0	0	0	0	0	0	7.95	0	0
2025	11	27	16	11	10	28	0	0	0	0	0	0	0	7.96	0	0
2025	11	27	16	21	10	28	0	0	0	0	0	0	0	7.98	0	0
2025	11	27	16	31	10	28	0	0	0	0	0	0	0	7.99	0	0
2025	11	27	16	41	10	28	0	0	0	0	0	0	0	8	0	0
2025	11	27	16	51	10	28	0	0	0	0	0	0	0	8.01	0	0
2025	11	27	17	1	10	27	0	0	0	0	0	0	0	8.02	0	0
2025	11	27	17	11	10	27	0	0	0	0	0	0	0	8.02	0	0
2025	11	27	17	21	10	28	0	0	0	0	0	0	0	8.01	0	0
2025	11	27	17	31	10	28	0	0	0	0	0	0	0	8.02	0	0
2025	11	27	17	41	10	27	0	0	0	0	0	0	0	8.02	0	0
2025	11	27	17	51	10	28	0	0	0	0	0	0	0	8.01	0	0
2025	11	27	18	1	10	28	0	0	0	0	0	0	0	8	0	0
2025	11	27	18	11	10	28	0	0	0	0	0	0	0	7.99	0	0
2025	11	27	18	21	10	28	0	0	0	0	0	0	0	7.98	0	0
2025	11	27	18	31	10	28	0	0	0	0	0	0	0	7.97	0	0
2025	11	27	18	41	10	28	0	0	0	0	0	0	0	7.95	0	0
2025	11	27	18	51	10	28	0	0	0	0	0	0	0	7.93	0	0
2025	11	27	19	1	10	27	0	0	0	0	0	0	0	7.91	0	0
2025	11	27	19	11	10	27	0	0	0	0	0	0	0	7.89	0	0
2025	11	27	19	21	10	28	0	0	0	0	0	0	0	7.86	0	0
2025	11	27	19	31	10	27	0	0	0	0	0	0	0	7.84	0	0
2025	11	27	19	41	10	28	0	0	0	0	0	0	0	7.81	0	0
2025	11	27	19	51	10	28	0	0	0	0	0	0	0	7.78	0	0
2025	11	27	20	1	10	27	0	0	0	0	0	0	0	7.75	0	0
2025	11	27	20	11	10	28	0	0	0	0	0	0	0	7.72	0	0
2025	11	27	20	21	10	28	0	0	0	0	0	0	0	7.69	0	0
2025	11	27	20	31	10	27	0	0	0	0	0	0	0	7.66	0	0
2025	11	27	20	41	10	28	0	0	0	0	0	0	0	7.63	0	0
2025	11	27	20	51	10	27	0	0	0	0	0	0	0	7.6	0	0
2025	11	27	21	1	10	27	0	0	0	0	0	0	0	7.56	0	0
2025	11	27	21	11	10	28	0	0	0	0	0	0	0	7.53	0	0
2025	11	27	21	21	10	28	0	0	0	0	0	0	0	7.5	0	0
2025	11	27	21	31	10	28	0	0	0	0	0	0	0	7.48	0	0
2025	11	27	21	41	10	27	0	0	0	0	0	0	0	7.44	0	0
2025	11	27	21	51	10	28	0	0	0	0	0	0	0	7.41	0	0
2025	11	27	22	1	10	28	0	0	0	0	0	0	0	7.38	0	0
2025	11	27	22	11	10	28	0	0	0	0	0	0	0	7.35	0	0
2025	11	27	22	21	10	28	0	0	0	0	0	0	0	7.33	0	0
2025	11	27	22	31	10	27	0	0	0	0	0	0	0	7.3	0	0
2025	11	27	22	41	10	28	0	0	0	0	0	0	0	7.27	0	0
2025	11	27	22	51	10	28	0	0	0	0	0	0	0	7.25	0	0
2025	11	27	23	1	10	28	0	0	0	0	0	0	0	7.21	0	0
2025	11	27	23	11	10	28	0	0	0	0	0	0	0	7.19	0	0
2025	11	27	23	21	10	28	0	0	0	0	0	0	0	7.16	0	0
2025	11	27	23	31	10	28	0	0	0	0	0	0	0	7.12	0	0
2025	11	27	23	41	10	27	0	0	0	0	0	0	0	7.1	0	0
2025	11	27	23	51	10	28	0	0	0	0	0	0	0	7.07	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	28	0	1	10	28	0	0	0	0	0	0	0	7.04	0	0
2025	11	28	0	11	10	28	0	0	0	0	0	0	0	7.01	0	0
2025	11	28	0	21	10	27	0	0	0	0	0	0	0	6.99	0	0
2025	11	28	0	31	10	27	0	0	0	0	0	0	0	6.96	0	0
2025	11	28	0	41	10	28	0	0	0	0	0	0	0	6.93	0	0
2025	11	28	0	51	10	28	0	0	0	0	0	0	0	6.9	0	0
2025	11	28	1	1	10	28	0	0	0	0	0	0	0	6.88	0	0
2025	11	28	1	11	10	27	0	0	0	0	0	0	0	6.85	0	0
2025	11	28	1	21	10	28	0	0	0	0	0	0	0	6.82	0	0
2025	11	28	1	31	10	28	0	0	0	0	0	0	0	6.8	0	0
2025	11	28	1	41	10	28	0	0	0	0	0	0	0	6.77	0	0
2025	11	28	1	51	10	28	0	0	0	0	0	0	0	6.75	0	0
2025	11	28	2	1	10	28	0	0	0	0	0	0	0	6.73	0	0
2025	11	28	2	11	10	29	0	0	0	0	0	0	0	6.7	0	0
2025	11	28	2	21	10	28	0	0	0	0	0	0	0	6.68	0	0
2025	11	28	2	31	10	28	0	0	0	0	0	0	0	6.67	0	0
2025	11	28	2	41	10	28	0	0	0	0	0	0	0	6.64	0	0
2025	11	28	2	51	10	28	0	0	0	0	0	0	0	6.62	0	0
2025	11	28	3	1	10	28	0	0	0	0	0	0	0	6.6	0	0
2025	11	28	3	11	10	28	0	0	0	0	0	0	0	6.58	0	0
2025	11	28	3	21	10	28	0	0	0	0	0	0	0	6.57	0	0
2025	11	28	3	31	10	28	0	0	0	0	0	0	0	6.54	0	0
2025	11	28	3	41	10	28	0	0	0	0	0	0	0	6.52	0	0
2025	11	28	3	51	10	28	0	0	0	0	0	0	0	6.51	0	0
2025	11	28	4	1	10	28	0	0	0	0	0	0	0	6.49	0	0
2025	11	28	4	11	10	28	0	0	0	0	0	0	0	6.47	0	0
2025	11	28	4	21	10	28	0	0	0	0	0	0	0	6.46	0	0
2025	11	28	4	31	10	28	0	0	0	0	0	0	0	6.44	0	0
2025	11	28	4	41	10	28	0	0	0	0	0	0	0	6.42	0	0
2025	11	28	4	51	10	28	0	0	0	0	0	0	0	6.4	0	0
2025	11	28	5	1	10	28	0	0	0	0	0	0	0	6.39	0	0
2025	11	28	5	11	10	28	0	0	0	0	0	0	0	6.38	0	0
2025	11	28	5	21	10	29	0	0	0	0	0	0	0	6.36	0	0
2025	11	28	5	31	10	28	0	0	0	0	0	0	0	6.35	0	0
2025	11	28	5	41	10	28	0	0	0	0	0	0	0	6.34	0	0
2025	11	28	5	51	10	28	0	0	0	0	0	0	0	6.33	0	0
2025	11	28	6	1	10	28	0	0	0	0	0	0	0	6.31	0	0
2025	11	28	6	11	10	28	0	0	0	0	0	0	0	6.3	0	0
2025	11	28	6	21	10	28	0	0	0	0	0	0	0	6.3	0	0
2025	11	28	6	31	10	28	0	0	0	0	0	0	0	6.28	0	0
2025	11	28	6	41	10	28	0	0	0	0	0	0	0	6.27	0	0
2025	11	28	6	51	10	29	0	0	0	0	0	0	0	6.26	0	0
2025	11	28	7	1	10	28	0	0	0	0	0	0	0	6.25	0	0
2025	11	28	7	11	10	28	0	0	0	0	0	0	0	6.24	0	0
2025	11	28	7	21	10	27	0	0	0	0	0	0	0	6.22	0	0
2025	11	28	7	31	10	28	0	0	0	0	0	0	0	6.22	0	0
2025	11	28	7	41	10	29	0	0	0	0	0	0	0	6.21	0	0
2025	11	28	7	51	10	28	0	0	0	0	0	0	0	6.2	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
2025	11	28	8	1	10	28	0	0	0	0	0	0	0	6.19	0	0
2025	11	28	8	11	10	28	0	0	0	0	0	0	0	6.18	0	0
2025	11	28	8	21	10	28	0	0	0	0	0	0	0	6.17	0	0
2025	11	28	8	31	10	28	0	0	0	0	0	0	0	6.17	0	0
2025	11	28	8	41	10	28	0	0	0	0	0	0	0	6.17	0	0
2025	11	28	8	51	10	29	0	0	0	0	0	0	0	6.18	0	0
2025	11	28	9	1	10	27	0	0	0	0	0	0	0	6.19	0	0
2025	11	28	9	11	10	29	0	0	0	0	0	0	0	6.2	0	0
2025	11	28	9	21	10	28	0	0	0	0	0	0	0	6.22	0	0
2025	11	28	9	31	10	28	0	0	0	0	0	0	0	6.24	0	0
2025	11	28	9	41	10	28	0	0	0	0	0	0	0	6.26	0	0
2025	11	28	9	51	10	28	0	0	0	0	0	0	0	6.28	0	0
2025	11	28	10	1	10	29	0	0	0	0	0	0	0	6.32	0	0
2025	11	28	10	11	10	28	0	0	0	0	0	0	0	6.35	0	0
2025	11	28	10	21	10	28	0	0	0	0	0	0	0	6.38	0	0
2025	11	28	10	31	10	28	0	0	0	0	0	0	0	6.43	0	0
2025	11	28	10	41	10	28	0	0	0	0	0	0	0	6.46	0	0
2025	11	28	10	51	10	28	0	0	0	0	0	0	0	6.51	0	0
2025	11	28	11	1	10	28	0	0	0	0	0	0	0	6.55	0	0
2025	11	28	11	11	10	28	0	0	0	0	0	0	0	6.6	0	0
2025	11	28	11	21	10	28	0	0	0	0	0	0	0	6.65	0	0
2025	11	28	11	31	10	28	0	0	0	0	0	0	0	6.7	0	0
2025	11	28	11	41	10	29	0	0	0	0	0	0	0	6.76	0	0
2025	11	28	11	51	10	28	0	0	0	0	0	0	0	6.82	0	0
2025	11	28	12	1	10	28	0	0	0	0	0	0	0	6.88	0	0
2025	11	28	12	11	10	28	0	0	0	0	0	0	0	6.93	0	0
2025	11	28	12	21	10	28	0	0	0	0	0	0	0	6.99	0	0
2025	11	28	12	31	10	27	0	0	0	0	0	0	0	7.05	0	0
2025	11	28	12	41	10	28	0	0	0	0	0	0	0	7.11	0	0
2025	11	28	12	51	10	29	0	0	0	0	0	0	0	7.17	0	0
2025	11	28	13	1	10	27	0	0	0	0	0	0	0	7.22	0	0
2025	11	28	13	11	10	28	0	0	0	0	0	0	0	7.28	0	0
2025	11	28	13	21	10	29	0	0	0	0	0	0	0	7.33	0	0
2025	11	28	13	31	10	28	0	0	0	0	0	0	0	7.38	0	0
2025	11	28	13	41	10	28	0	0	0	0	0	0	0	7.44	0	0
2025	11	28	13	51	10	27	0	0	0	0	0	0	0	7.48	0	0
2025	11	28	14	1	10	28	0	0	0	0	0	0	0	7.53	0	0
2025	11	28	14	11	10	28	0	0	0	0	0	0	0	7.58	0	0
2025	11	28	14	21	10	28	0	0	0	0	0	0	0	7.62	0	0
2025	11	28	14	31	10	27	0	0	0	0	0	0	0	7.66	0	0
2025	11	28	14	41	10	28	0	0	0	0	0	0	0	7.69	0	0
2025	11	28	14	51	10	27	0	0	0	0	0	0	0	7.73	0	0
2025	11	28	15	1	10	27	0	0	0	0	0	0	0	7.76	0	0
2025	11	28	15	11	10	28	0	0	0	0	0	0	0	7.79	0	0
2025	11	28	15	21	10	28	0	0	0	0	0	0	0	7.83	0	0
2025	11	28	15	31	10	28	0	0	0	0	0	0	0	7.85	0	0
2025	11	28	15	41	10	28	0	0	0	0	0	0	0	7.87	0	0
2025	11	28	15	51	10	28	0	0	0	0	0	0	0	7.89	0	0

Mazourka (0354)

[illegible]

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	11	29	16	1	10	28	0	0	0	0	0	0	0	7.63	0	0
	2025	11	29	16	11	10	28	0	0	0	0	0	0	0	7.64	0	0
	2025	11	29	16	21	10	27	0	0	0	0	0	0	0	7.65	0	0
	2025	11	29	16	31	10	28	0	0	0	0	0	0	0	7.67	0	0
	2025	11	29	16	41	10	28	0	0	0	0	0	0	0	7.67	0	0
	2025	11	29	16	51	10	28	0	0	0	0	0	0	0	7.68	0	0
	2025	11	29	17	1	10	28	0	0	0	0	0	0	0	7.69	0	0
	2025	11	29	17	11	10	28	0	0	0	0	0	0	0	7.69	0	0
	2025	11	29	17	21	10	27	0	0	0	0	0	0	0	7.69	0	0
	2025	11	29	17	31	10	28	0	0	0	0	0	0	0	7.69	0	0
	2025	11	29	17	41	10	28	0	0	0	0	0	0	0	7.68	0	0
	2025	11	29	17	51	10	28	0	0	0	0	0	0	0	7.67	0	0
	2025	11	29	18	1	10	28	0	0	0	0	0	0	0	7.67	0	0
	2025	11	29	18	11	10	28	0	0	0	0	0	0	0	7.65	0	0
	2025	11	29	18	21	10	28	0	0	0	0	0	0	0	7.64	0	0
	2025	11	29	18	31	10	28	0	0	0	0	0	0	0	7.63	0	0
	2025	11	29	18	41	10	28	0	0	0	0	0	0	0	7.62	0	0
	2025	11	29	18	51	10	28	0	0	0	0	0	0	0	7.59	0	0
	2025	11	29	19	1	10	28	0	0	0	0	0	0	0	7.58	0	0
	2025	11	29	19	11	10	28	0	0	0	0	0	0	0	7.55	0	0
	2025	11	29	19	21	10	27	0	0	0	0	0	0	0	7.53	0	0
	2025	11	29	19	31	10	27	0	0	0	0	0	0	0	7.51	0	0
	2025	11	29	19	41	10	28	0	0	0	0	0	0	0	7.48	0	0
	2025	11	29	19	51	10	28	0	0	0	0	0	0	0	7.45	0	0
	2025	11	29	20	1	10	28	0	0	0	0	0	0	0	7.43	0	0
	2025	11	29	20	11	10	28	0	0	0	0	0	0	0	7.4	0	0
	2025	11	29	20	21	10	28	0	0	0	0	0	0	0	7.37	0	0
	2025	11	29	20	31	10	28	0	0	0	0	0	0	0	7.34	0	0
	2025	11	29	20	41	10	28	0	0	0	0	0	0	0	7.31	0	0
	2025	11	29	20	51	10	28	0	0	0	0	0	0	0	7.28	0	0
	2025	11	29	21	1	10	28	0	0	0	0	0	0	0	7.25	0	0
	2025	11	29	21	11	10	27	0	0	0	0	0	0	0	7.22	0	0
	2025	11	29	21	21	10	28	0	0	0	0	0	0	0	7.19	0	0
	2025	11	29	21	31	10	28	0	0	0	0	0	0	0	7.17	0	0
	2025	11	29	21	41	10	28	0	0	0	0	0	0	0	7.13	0	0
	2025	11	29	21	51	10	28	0	0	0	0	0	0	0	7.1	0	0
	2025	11	29	22	1	10	28	0	0	0	0	0	0	0	7.07	0	0
	2025	11	29	22	11	10	28	0	0	0	0	0	0	0	7.05	0	0
	2025	11	29	22	21	10	28	0	0	0	0	0	0	0	7.02	0	0
	2025	11	29	22	31	10	28	0	0	0	0	0	0	0	7	0	0
	2025	11	29	22	41	10	27	0	0	0	0	0	0	0	6.97	0	0
	2025	11	29	22	51	10	28	0	0	0	0	0	0	0	6.95	0	0
	2025	11	29	23	1	10	28	0	0	0	0	0	0	0	6.92	0	0
	2025	11	29	23	11	10	28	0	0	0	0	0	0	0	6.9	0	0
	2025	11	29	23	21	10	28	0	0	0	0	0	0	0	6.87	0	0
	2025	11	29	23	31	10	28	0	0	0	0	0	0	0	6.85	0	0
	2025	11	29	23	41	10	28	0	0	0	0	0	0	0	6.82	0	0
	2025	11	29	23	51	10	28	0	0	0	0	0	0	0	6.79	0	0

Mazourka (0354)

	Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure
	2025	11	30	16	1	10	28	0	0	0	0	0	0	0	7.12	0	0
	2025	11	30	16	11	10	27	0	0	0	0	0	0	0	7.12	0	0
	2025	11	30	16	21	10	28	0	0	0	0	0	0	0	7.13	0	0
	2025	11	30	16	31	10	28	0	0	0	0	0	0	0	7.13	0	0
	2025	11	30	16	41	10	28	0	0	0	0	0	0	0	7.14	0	0
	2025	11	30	16	51	10	28	0	0	0	0	0	0	0	7.14	0	0
	2025	11	30	17	1	10	28	0	0	0	0	0	0	0	7.14	0	0
	2025	11	30	17	11	10	27	0	0	0	0	0	0	0	7.15	0	0
	2025	11	30	17	21	10	28	0	0	0	0	0	0	0	7.15	0	0
	2025	11	30	17	31	10	28	0	0	0	0	0	0	0	7.14	0	0
	2025	11	30	17	41	10	28	0	0	0	0	0	0	0	7.14	0	0
	2025	11	30	17	51	10	28	0	0	0	0	0	0	0	7.13	0	0
	2025	11	30	18	1	10	28	0	0	0	0	0	0	0	7.13	0	0
	2025	11	30	18	11	10	28	0	0	0	0	0	0	0	7.12	0	0
	2025	11	30	18	21	10	28	0	0	0	0	0	0	0	7.11	0	0
	2025	11	30	18	31	10	28	0	0	0	0	0	0	0	7.1	0	0
	2025	11	30	18	41	10	28	0	0	0	0	0	0	0	7.08	0	0
	2025	11	30	18	51	10	28	0	0	0	0	0	0	0	7.06	0	0
	2025	11	30	19	1	10	28	0	0	0	0	0	0	0	7.04	0	0
	2025	11	30	19	11	10	28	0	0	0	0	0	0	0	7.03	0	0
	2025	11	30	19	21	10	28	0	0	0	0	0	0	0	7	0	0
	2025	11	30	19	31	10	29	0	0	0	0	0	0	0	6.98	0	0
	2025	11	30	19	41	10	28	0	0	0	0	0	0	0	6.96	0	0
	2025	11	30	19	51	10	28	0	0	0	0	0	0	0	6.93	0	0
	2025	11	30	20	1	10	28	0	0	0	0	0	0	0	6.91	0	0
	2025	11	30	20	11	10	28	0	0	0	0	0	0	0	6.88	0	0
	2025	11	30	20	21	10	27	0	0	0	0	0	0	0	6.85	0	0
	2025	11	30	20	31	10	28	0	0	0	0	0	0	0	6.83	0	0
	2025	11	30	20	41	10	27	0	0	0	0	0	0	0	6.8	0	0
	2025	11	30	20	51	10	28	0	0	0	0	0	0	0	6.76	0	0
	2025	11	30	21	1	10	28	0	0	0	0	0	0	0	6.74	0	0
	2025	11	30	21	11	10	28	0	0	0	0	0	0	0	6.7	0	0
	2025	11	30	21	21	10	28	0	0	0	0	0	0	0	6.68	0	0
	2025	11	30	21	31	10	29	0	0	0	0	0	0	0	6.65	0	0
	2025	11	30	21	41	10	28	0	0	0	0	0	0	0	6.62	0	0
	2025	11	30	21	51	10	28	0	0	0	0	0	0	0	6.59	0	0
	2025	11	30	22	1	10	28	0	0	0	0	0	0	0	6.57	0	0
	2025	11	30	22	11	10	28	0	0	0	0	0	0	0	6.54	0	0
	2025	11	30	22	21	10	27	0	0	0	0	0	0	0	6.51	0	0
	2025	11	30	22	31	10	28	0	0	0	0	0	0	0	6.49	0	0
	2025	11	30	22	41	10	28	0	0	0	0	0	0	0	6.47	0	0
	2025	11	30	22	51	10	28	0	0	0	0	0	0	0	6.44	0	0
	2025	11	30	23	1	10	27	0	0	0	0	0	0	0	6.42	0	0
	2025	11	30	23	11	10	29	0	0	0	0	0	0	0	6.4	0	0
	2025	11	30	23	21	10	28	0	0	0	0	0	0	0	6.38	0	0
	2025	11	30	23	31	10	28	0	0	0	0	0	0	0	6.36	0	0
	2025	11	30	23	41	10	28	0	0	0	0	0	0	0	6.35	0	0
	2025	11	30	23	51	10	28	0	0	0	0	0	0	0	6.32	0	0

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	1	0	0	0	12	0.1	0.9	26.85	93.6	6.3057	55.9789
2025	11	1	0	10	0	12	0.1	0.9	27.08	94.4	6.3057	56.3967
2025	11	1	0	20	0	12	0.1	0.9	25.2	90.9	6.3057	52.6369
2025	11	1	0	30	0	12	0.1	0.9	27.6	95	6.3057	57.4411
2025	11	1	0	40	0	12	0.1	0.9	25.79	94.9	6.3057	53.6814
2025	11	1	0	50	0	12	0.1	0.9	27.17	94.2	6.3057	56.6057
2025	11	1	1	0	0	12	0.1	0.9	26.75	93.4	6.3057	55.7702
2025	11	1	1	10	0	12	0.1	0.9	26.32	95.5	6.3057	54.7258
2025	11	1	1	20	0	12	0.1	0.9	27.99	94.7	6.3057	58.2768
2025	11	1	1	30	0	12	0.1	0.9	27.05	93.4	6.3057	56.3969
2025	11	1	1	40	0	12	0.1	0.9	27.05	93.6	6.3057	56.3969
2025	11	1	1	50	0	12	0.1	0.9	27.95	93.5	6.3057	58.2769
2025	11	1	2	0	0	12	0.1	0.9	26.16	93.7	6.3057	54.5171
2025	11	1	2	10	0	11.8	0.1	0.9	26.77	94.3	6.3057	55.7704
2025	11	1	2	20	0	11.8	0.1	0.9	26.73	92.8	6.3057	55.7704
2025	11	1	2	30	0	11.8	0.1	0.9	26.64	93	6.3057	55.5616
2025	11	1	2	40	0	11.8	0.1	0.9	27.47	94	6.3057	57.2326
2025	11	1	2	50	0	11.8	0.1	0.9	27.26	93.8	6.3057	56.8149
2025	11	1	3	0	0	11.8	0.1	0.9	26.18	94.4	6.2996	54.4623
2025	11	1	3	10	0	11.8	0.1	0.9	26.08	94.6	6.3057	54.3084
2025	11	1	3	20	0	11.8	0.1	0.9	26.24	93.3	6.3057	54.7262
2025	11	1	3	30	0	11.8	0.1	0.9	25.82	92	6.3057	53.8907
2025	11	1	3	40	0	11.8	0.1	0.9	27.15	93.6	6.3057	56.6061
2025	11	1	3	50	0	11.8	0.1	0.9	26.23	92.8	6.3057	54.7262
2025	11	1	4	0	0	11.8	0.1	0.9	26.55	93.7	6.3057	55.3529
2025	11	1	4	10	0	11.8	0.1	0.9	26.65	96	6.3057	55.3529
2025	11	1	4	20	0	11.8	0.1	0.9	26.67	94.1	6.3057	55.5618
2025	11	1	4	30	0	11.8	0.1	0.9	26.78	94.5	6.3057	55.7707
2025	11	1	4	40	0	11.8	0.1	0.9	26.87	94.1	6.3057	55.9796
2025	11	1	4	50	0	11.8	0.1	0.9	27.06	93.8	6.3057	56.3973
2025	11	1	5	0	0	11.8	0.1	0.9	27.17	94	6.3057	56.6062
2025	11	1	5	10	0	11.8	0.1	0.9	26.91	95.1	6.3057	55.9796
2025	11	1	5	20	0	11.8	0.1	0.9	27.21	95.1	6.3057	56.6063
2025	11	1	5	30	0	11.8	0.1	0.9	25.84	97.8	6.3057	53.4731
2025	11	1	5	40	0	11.8	0.1	0.9	27.74	92.9	6.3057	57.8596
2025	11	1	5	50	0	11.8	0.1	0.9	27.91	95.1	6.3057	58.0685
2025	11	1	6	0	0	11.8	0.1	0.9	27.02	95.3	6.3057	56.1886
2025	11	1	6	10	0	11.8	0.1	0.9	26.79	96.9	6.3057	55.5619
2025	11	1	6	20	0	11.8	0.1	0.9	26.16	93.7	6.3057	54.5176
2025	11	1	6	30	0	11.8	0.1	0.9	27.49	94.6	6.3118	57.2907
2025	11	1	6	40	0	11.8	0.1	0.9	27.44	95.9	6.3057	57.0241
2025	11	1	6	50	0	11.8	0.1	0.9	27.65	93.5	6.3118	57.7089
2025	11	1	7	0	0	11.8	0.1	0.9	26.73	92.8	6.3118	55.8271
2025	11	1	7	10	0	11.8	0.1	0.9	26.73	92.8	6.3179	55.8834
2025	11	1	7	20	0	11.8	0.1	0.9	24.93	92.8	6.3118	52.0635
2025	11	1	7	30	0	11.8	0.1	0.9	26.83	92.8	6.3118	56.0363
2025	11	1	7	40	0	11.6	0.1	0.9	26.65	93.7	6.3179	55.6741
2025	11	1	7	50	0	11.6	0.1	0.9	26.48	94.3	6.3179	55.2555

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	1	8	0	0	11.6	0.1	0.9	26.42	92.2	6.324	55.3112
2025	11	1	8	10	0	12.2	0.1	0.9	26.55	93.7	6.3179	55.4648
2025	11	1	8	20	0	12.6	0.1	0.9	26.26	93.9	6.3179	54.8369
2025	11	1	8	30	0	12.8	0.1	0.9	26.15	96.1	6.3179	54.4184
2025	11	1	8	40	0	13	0.1	0.9	26.37	94.1	6.3179	55.0463
2025	11	1	8	50	0	13	0.1	0.9	26.47	94.1	6.3179	55.2555
2025	11	1	9	0	0	13	0.1	0.9	26.27	96.6	6.3179	54.6276
2025	11	1	9	10	0	13	0.1	0.9	25.09	94.8	6.3179	52.3253
2025	11	1	9	20	0	13	0.1	0.9	26.76	96.2	6.3179	55.6741
2025	11	1	9	30	0	13	0.1	0.9	25.69	94.7	6.3118	53.5272
2025	11	1	9	40	0	13.2	0.1	0.9	25.61	91.6	6.3118	53.5271
2025	11	1	9	50	0	13.2	0.1	0.9	25.92	95.5	6.3179	53.9996
2025	11	1	10	0	0	13.2	0.1	0.9	26.17	96.6	6.3179	54.4182
2025	11	1	10	10	0	13.2	0.1	0.9	26.99	94.7	6.3179	56.3019
2025	11	1	10	20	0	13.6	0.1	0.9	26.44	93.3	6.3118	55.1997
2025	11	1	10	30	0	14.2	0.1	0.9	25.98	94.6	6.3118	54.1542
2025	11	1	10	40	0	14.2	0.1	0.9	26.69	94.7	6.3118	55.6178
2025	11	1	10	50	0	14.2	0.1	0.9	27.23	95.7	6.3057	56.6061
2025	11	1	11	0	0	14.2	0.1	0.9	26.35	93.7	6.3057	54.935
2025	11	1	11	10	0	14.2	0.1	0.9	26.88	94.5	6.3057	55.9794
2025	11	1	11	20	0	14	0.1	0.9	26.23	92.8	6.3057	54.7261
2025	11	1	11	30	0	14.2	0.1	0.9	25.96	96.4	6.3057	53.8905
2025	11	1	11	40	0	14.2	0.1	0.9	27.06	93.8	6.3057	56.397
2025	11	1	11	50	0	14.2	0.1	0.9	27.21	95.1	6.3057	56.6058
2025	11	1	12	0	0	14.2	0.1	0.9	27	94.9	6.3057	56.188
2025	11	1	12	10	0	14.2	0.1	0.9	25.59	94.7	6.3057	53.2636
2025	11	1	12	20	0	14.2	0.1	0.9	26.27	96.6	6.3057	54.5169
2025	11	1	12	30	0	14.2	0.1	0.9	26.32	95.5	6.3057	54.7257
2025	11	1	12	40	0	14.2	0.1	0.9	26.89	94.7	6.3057	55.9789
2025	11	1	12	50	0	14.2	0.1	0.9	26.5	95	6.3057	55.1433
2025	11	1	13	0	0	14.2	0.1	0.9	25.61	95.4	6.3057	53.2634
2025	11	1	13	10	0	14.2	0.1	0.9	26.45	96.1	6.3057	54.9344
2025	11	1	13	20	0	14.2	0.1	0.9	26.86	96.2	6.3118	55.826
2025	11	1	13	30	0	14.2	0.1	0.9	27.39	96.7	6.3057	56.8141
2025	11	1	13	40	0	14.2	0.1	0.9	25.06	93.9	6.3118	52.2715
2025	11	1	13	50	0	14.2	0.1	0.9	26.58	94.3	6.3118	55.4077
2025	11	1	14	0	0	14.2	0.1	0.9	26.01	95.3	6.3118	54.1532
2025	11	1	14	10	0	14.2	0.1	0.9	26.53	95.6	6.3118	55.1986
2025	11	1	14	20	0	14.2	0.1	0.9	27.53	95.6	6.3057	57.2316
2025	11	1	14	30	0	14.2	0.1	0.9	25.4	95	6.3118	52.8985
2025	11	1	14	40	0	14.2	0.1	0.9	27.37	94.2	6.3118	57.0802
2025	11	1	14	50	0	14.2	0.1	0.9	27.36	93.8	6.3057	57.0227
2025	11	1	15	0	0	14	0.1	0.9	26.85	93.6	6.3057	55.9782
2025	11	1	15	10	0	14	0.1	0.9	27.07	94.2	6.3118	56.4528
2025	11	1	15	20	0	13.6	0.1	0.9	26.3	95	6.3118	54.7801
2025	11	1	15	30	0	13.8	0.1	0.9	26.31	95.2	6.3118	54.7801
2025	11	1	15	40	0	13.8	0.1	0.9	27.1	94.9	6.3118	56.4528
2025	11	1	15	50	0	13.8	0.1	0.9	25.78	94.4	6.3118	53.7346

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	1	16	0	0	13.6	0.1	0.9	25.69	96.9	6.3118	53.3165
2025	11	1	16	10	0	13.6	0.1	0.9	26.77	94.1	6.3118	55.8254
2025	11	1	16	20	0	13.2	0.1	0.9	26.09	94.8	6.3118	54.3619
2025	11	1	16	30	0	13.2	0.1	0.9	26.59	94.7	6.3118	55.4073
2025	11	1	16	40	0	13.2	0.1	0.9	26.12	95.5	6.3118	54.3618
2025	11	1	16	50	0	13.2	0.1	0.9	26.71	95.2	6.3118	55.6163
2025	11	1	17	0	0	13.2	0.1	0.9	26.2	90	6.3118	54.78
2025	11	1	17	10	0	12.6	0.1	0.9	26.38	94.3	6.3118	54.989
2025	11	1	17	20	0	12.2	0.1	0.9	27.15	93.6	6.3118	56.6617
2025	11	1	17	30	0	12.2	0.1	0.9	27.23	95.7	6.3118	56.6617
2025	11	1	17	40	0	12.2	0.1	0.9	26.82	91.9	6.3118	56.0345
2025	11	1	17	50	0	12.2	0.1	0.9	27.7	95	6.3118	57.7071
2025	11	1	18	0	0	12.2	0.1	0.9	25.71	95.4	6.3118	53.5255
2025	11	1	18	10	0	12.2	0.1	0.9	27.02	92.1	6.3118	56.4526
2025	11	1	18	20	0	12.2	0.1	0.9	27.23	92.7	6.3179	56.9281
2025	11	1	18	30	0	12.2	0.1	0.9	26.65	93.7	6.3179	55.6723
2025	11	1	18	40	0	12.2	0.1	0.9	26.9	94.9	6.3118	56.0345
2025	11	1	18	50	0	12.2	0.1	0.9	27.11	91.5	6.3118	56.6618
2025	11	1	19	0	0	12.2	0.1	0.9	26.69	94.7	6.3118	55.6164
2025	11	1	19	10	0	12	0.1	0.9	26.54	93.2	6.3179	55.4631
2025	11	1	19	20	0	12	0.1	0.9	26.75	93.4	6.3118	55.8255
2025	11	1	19	30	0	12	0.1	0.9	26.75	93.6	6.3118	55.8255
2025	11	1	19	40	0	12	0.1	0.9	28.34	93	6.3118	59.1709
2025	11	1	19	50	0	12	0.1	0.9	25.95	93.5	6.3118	54.1529
2025	11	1	20	0	0	12	0.1	0.9	27.15	93.6	6.3118	56.6619
2025	11	1	20	10	0	12	0.1	0.9	26.56	93.9	6.3118	55.4075
2025	11	1	20	20	0	12	0.1	0.9	25.73	92.9	6.3118	53.7348
2025	11	1	20	30	0	12	0.1	0.9	27.41	91.9	6.3118	57.2893
2025	11	1	20	40	0	12	0.1	0.9	27.52	95.4	6.3118	57.2893
2025	11	1	20	50	0	12	0.1	0.9	27.08	94.4	6.3118	56.453
2025	11	1	21	0	0	12	0.1	0.9	26.78	96.6	6.3118	55.6167
2025	11	1	21	10	0	12	0.1	0.9	27.05	93.6	6.3118	56.4531
2025	11	1	21	20	0	12	0.1	0.9	26.57	94.1	6.3118	55.4077
2025	11	1	21	30	0	12	0.1	0.9	27.25	93.6	6.3118	56.8713
2025	11	1	21	40	0	12	0.1	0.9	26.88	94.5	6.3118	56.035
2025	11	1	21	50	0	12	0.1	0.9	26.72	92.4	6.3118	55.8259
2025	11	1	22	0	0	12	0.1	0.9	26.14	93.1	6.3118	54.5714
2025	11	1	22	10	0	12	0.1	0.9	26.44	93	6.3118	55.1987
2025	11	1	22	20	0	12	0.1	0.9	25.99	94.9	6.3118	54.1533
2025	11	1	22	30	0	12	0.1	0.9	27.35	93.6	6.3118	57.0806
2025	11	1	22	40	0	12	0.1	0.9	26.18	94.6	6.3118	54.5716
2025	11	1	22	50	0	12	0.1	0.9	25.54	93.4	6.3118	53.3171
2025	11	1	23	0	0	12	0.1	0.9	26.73	92.8	6.3118	55.8261
2025	11	1	23	10	0	12	0.1	0.9	26.16	93.9	6.3118	54.5717
2025	11	1	23	20	0	12	0.1	0.9	27.05	93.4	6.3118	56.4535
2025	11	1	23	30	0	12	0.1	0.9	26.48	94.3	6.3118	55.199
2025	11	1	23	40	0	12	0.1	0.9	25.43	92.9	6.3057	53.0546
2025	11	1	23	50	0	12	0.1	0.9	27.03	92.8	6.3118	56.4535

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	2	0	0	0	12	0.1	0.9	26.32	92.2	6.3118	54.99
2025	11	2	0	10	0	12	0.1	0.9	27.25	93.4	6.3057	56.8145
2025	11	2	0	20	0	11.8	0.1	0.9	26.82	95.3	6.3057	55.7701
2025	11	2	0	30	0	11.8	0.1	0.9	26.92	95.3	6.3057	55.979
2025	11	2	0	40	0	11.8	0.1	0.9	25.91	95.3	6.3057	53.8903
2025	11	2	0	50	0	11.8	0.1	0.9	27.39	94.6	6.3057	57.0235
2025	11	2	1	0	0	11.8	0.1	0.9	27.22	95.5	6.3057	56.6058
2025	11	2	1	10	0	11.8	0.1	0.9	26.88	94.5	6.3057	55.9792
2025	11	2	1	20	0	11.8	0.1	0.9	27.08	94.4	6.3057	56.3969
2025	11	2	1	30	0	11.8	0.1	0.9	27.23	92.5	6.3057	56.8147
2025	11	2	1	40	0	11.8	0.1	0.9	26.78	94.5	6.3057	55.7704
2025	11	2	1	50	0	11.8	0.1	0.9	25.89	94.7	6.3057	53.8905
2025	11	2	2	0	0	11.8	0.1	0.9	26.73	92.8	6.3057	55.7704
2025	11	2	2	10	0	11.8	0.1	0.9	26.8	94.9	6.3057	55.7704
2025	11	2	2	20	0	11.8	0.1	0.9	26.62	95.4	6.3057	55.3527
2025	11	2	2	30	0	11.8	0.1	0.9	27.43	92.7	6.3057	57.2326
2025	11	2	2	40	0	11.8	0.1	0.9	25.21	91.8	6.3057	52.6374
2025	11	2	2	50	0	11.8	0.1	0.9	26.65	93.4	6.3057	55.5617
2025	11	2	3	0	0	11.8	0.1	0.9	27.47	94	6.3057	57.2327
2025	11	2	3	10	0	11.8	0.1	0.9	26.04	93.1	6.3057	54.3084
2025	11	2	3	20	0	11.8	0.1	0.9	26.59	94.7	6.3057	55.3529
2025	11	2	3	30	0	11.8	0.1	0.9	26.48	94.3	6.3057	55.144
2025	11	2	3	40	0	11.8	0.1	0.9	26.53	92.6	6.3057	55.3529
2025	11	2	3	50	0	11.8	0.1	0.9	26.98	94.5	6.3057	56.1884
2025	11	2	4	0	0	11.8	0.1	0.9	26.11	91.8	6.3057	54.5174
2025	11	2	4	10	0	11.8	0.1	0.9	26.91	95.1	6.3057	55.9796
2025	11	2	4	20	0	11.8	0.1	0.9	26.35	93.5	6.2996	54.8798
2025	11	2	4	30	0	11.8	0.1	0.9	26.65	93.4	6.3057	55.5619
2025	11	2	4	40	0	11.8	0.1	0.9	26.74	93.2	6.2996	55.7145
2025	11	2	4	50	0	11.8	0.1	0.9	27.23	92.7	6.3057	56.8152
2025	11	2	5	0	0	11.8	0.1	0.9	26.52	95.4	6.3057	55.1441
2025	11	2	5	10	0	11.8	0.1	0.9	26.33	95.7	6.3057	54.7264
2025	11	2	5	20	0	11.8	0.1	0.9	27.89	94.7	6.3057	58.0685
2025	11	2	5	30	0	11.8	0.1	0.9	26.37	94.1	6.3057	54.9353
2025	11	2	5	40	0	11.8	0.1	0.9	26.37	94.1	6.3057	54.9353
2025	11	2	5	50	0	11.8	0.1	0.9	26.95	93.6	6.3057	56.1886
2025	11	2	6	0	0	11.8	0.1	0.9	26.65	93.4	6.3057	55.562
2025	11	2	6	10	0	11.8	0.1	0.9	25.71	91.8	6.3057	53.6821
2025	11	2	6	20	0	11.8	0.1	0.9	26.87	94.3	6.3057	55.9798
2025	11	2	6	30	0	11.8	0.1	0.9	25.64	93.1	6.3118	53.5272
2025	11	2	6	40	0	11.8	0.1	0.9	26.38	96.7	6.3118	54.7817
2025	11	2	6	50	0	11.6	0.1	0.9	25.66	93.8	6.3179	53.5811
2025	11	2	7	0	0	11.6	0.1	0.9	27.57	94.2	6.3118	57.4999
2025	11	2	7	10	0	11.6	0.1	0.9	27.5	95	6.3118	57.2909
2025	11	2	7	20	0	11.6	0.1	0.9	26.9	90.6	6.3179	56.3021
2025	11	2	7	30	0	11.6	0.1	0.9	26.39	94.8	6.3179	55.0463
2025	11	2	7	40	0	11.6	0.1	0.9	26.93	92.8	6.3179	56.3021
2025	11	2	7	50	0	11.6	0.1	0.9	26.53	92.8	6.3179	55.4649

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	2	8	0	0	11.6	0.1	0.9	26.74	95.8	6.3179	55.6742
2025	11	2	8	10	0	12	0.1	0.9	27.22	95.3	6.324	56.7778
2025	11	2	8	20	0	12.6	0.1	0.9	26.2	91.1	6.3179	54.837
2025	11	2	8	30	0	12.8	0.1	0.9	26.21	91.5	6.324	54.8923
2025	11	2	8	40	0	13	0.1	0.9	26.85	93.6	6.324	56.1493
2025	11	2	8	50	0	13.4	0.1	0.9	26.54	93.2	6.324	55.5208
2025	11	2	9	0	0	13.6	0.1	0.9	26.03	95.7	6.324	54.2637
2025	11	2	9	10	0	13.6	0.1	0.9	26.84	93.2	6.324	56.1493
2025	11	2	9	20	0	13.4	0.1	0.9	27.64	93.1	6.324	57.8254
2025	11	2	9	30	0	13.4	0.1	0.9	26.97	94	6.324	56.3588
2025	11	2	9	40	0	13.4	0.1	0.9	25.73	92.9	6.324	53.8446
2025	11	2	9	50	0	13.4	0.1	0.9	26.52	95.4	6.324	55.3112
2025	11	2	10	0	0	13.8	0.1	0.9	26.77	94.3	6.324	55.9397
2025	11	2	10	10	0	14.2	0.1	0.9	26.06	94	6.324	54.4731
2025	11	2	10	20	0	14.2	0.1	0.9	26.01	91.8	6.324	54.473
2025	11	2	10	30	0	14.2	0.1	0.9	26.05	93.5	6.324	54.473
2025	11	2	10	40	0	14.2	0.1	0.9	27.34	93.1	6.324	57.1966
2025	11	2	10	50	0	14.2	0.1	0.9	26.61	95.2	6.3301	55.5763
2025	11	2	11	0	0	14.2	0.1	0.9	26.55	93.7	6.3301	55.5763
2025	11	2	11	10	0	14.2	0.1	0.9	26.3	95	6.324	54.8919
2025	11	2	11	20	0	14	0.1	0.9	26.41	95.2	6.324	55.1013
2025	11	2	11	30	0	14.2	0.1	0.9	27.73	95.6	6.324	57.8249
2025	11	2	11	40	0	14	0.1	0.9	27.63	92.7	6.324	57.8248
2025	11	2	11	50	0	14.2	0.1	0.9	26.09	94.8	6.324	54.4726
2025	11	2	12	0	0	14.2	0.1	0.9	26.91	95.1	6.324	56.1487
2025	11	2	12	10	0	14	0.1	0.9	26.16	93.7	6.324	54.682
2025	11	2	12	20	0	13.8	0.1	0.9	26.96	93.8	6.3179	56.3014
2025	11	2	12	30	0	14	0.1	0.9	26.66	93.9	6.3179	55.6735
2025	11	2	12	40	0	13.8	0.1	0.9	27.53	92.7	6.3179	57.5571
2025	11	2	12	50	0	13.8	0.1	0.9	26.85	93.4	6.3118	56.0355
2025	11	2	13	0	0	13.8	0.1	0.9	26.89	94.7	6.3118	56.0355
2025	11	2	13	10	0	13.8	0.1	0.9	26.07	94.2	6.3118	54.3627
2025	11	2	13	20	0	13.6	0.1	0.9	26.87	96.4	6.3118	55.8263
2025	11	2	13	30	0	13.6	0.1	0.9	25.81	95.3	6.3118	53.7354
2025	11	2	13	40	0	13.8	0.1	0.9	26.45	93.7	6.3118	55.1989
2025	11	2	13	50	0	13.8	0.1	0.9	27.28	94.4	6.3118	56.8716
2025	11	2	14	0	0	13.6	0.1	0.9	26.83	92.8	6.3118	56.0352
2025	11	2	14	10	0	13.8	0.1	0.9	26.04	96	6.3118	54.1534
2025	11	2	14	20	0	13.6	0.1	0.9	26.45	93.5	6.3118	55.1988
2025	11	2	14	30	0	13.8	0.1	0.9	26.77	94.1	6.3118	55.826
2025	11	2	14	40	0	13.8	0.1	0.9	25.69	94.9	6.3118	53.526
2025	11	2	14	50	0	13.8	0.1	0.9	26.85	93.6	6.3118	56.035
2025	11	2	15	0	0	13.8	0.1	0.9	26.4	95	6.3118	54.9895
2025	11	2	15	10	0	13.8	0.1	0.9	26.75	93.4	6.3179	55.8821
2025	11	2	15	20	0	13.6	0.1	0.9	27.45	93.6	6.3118	57.2894
2025	11	2	15	30	0	13.6	0.1	0.9	27.87	94.1	6.3118	58.1257
2025	11	2	15	40	0	13.6	0.1	0.9	27.38	94.4	6.3118	57.0803
2025	11	2	15	50	0	13.6	0.1	0.9	26.27	94.1	6.3179	54.8355

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	2	16	0	0	13.6	0.1	0.9	26.85	93.6	6.3118	56.0348
2025	11	2	16	10	0	13.4	0.1	0.9	27.13	95.7	6.3118	56.453
2025	11	2	16	20	0	13.4	0.1	0.9	26.83	95.6	6.3118	55.8257
2025	11	2	16	30	0	13.4	0.1	0.9	27.22	95.3	6.3179	56.7191
2025	11	2	16	40	0	13.4	0.1	0.9	26.62	95.4	6.3179	55.4633
2025	11	2	16	50	0	13.2	0.1	0.9	26.4	95	6.3118	54.9893
2025	11	2	17	0	0	13.2	0.1	0.9	27.83	92.5	6.3179	58.1841
2025	11	2	17	10	0	11.8	0.1	0.9	26.48	94.5	6.3179	55.254
2025	11	2	17	20	0	12.2	0.1	0.9	26.86	93.8	6.3179	56.0912
2025	11	2	17	30	0	12.2	0.1	0.9	27.9	94.9	6.3179	58.1841
2025	11	2	17	40	0	12.2	0.1	0.9	27.11	91.5	6.3179	56.7191
2025	11	2	17	50	0	12.2	0.1	0.9	26.65	93.7	6.3179	55.6726
2025	11	2	18	0	0	12.2	0.1	0.9	27.41	91.9	6.3179	57.3469
2025	11	2	18	10	0	12.2	0.1	0.9	27.36	93.8	6.3179	57.1377
2025	11	2	18	20	0	12.2	0.1	0.9	25.45	93.6	6.3179	53.161
2025	11	2	18	30	0	12.2	0.1	0.9	26.56	93.9	6.3179	55.4633
2025	11	2	18	40	0	12.2	0.1	0.9	25.66	93.8	6.3179	53.5797
2025	11	2	18	50	0	12.2	0.1	0.9	26.84	93.2	6.3179	56.0912
2025	11	2	19	0	0	12.2	0.1	0.9	26.71	95.2	6.3179	55.6726
2025	11	2	19	10	0	12.2	0.1	0.9	27	90.8	6.3179	56.5098
2025	11	2	19	20	0	12	0.1	0.9	26.33	92.8	6.3179	55.0448
2025	11	2	19	30	0	12	0.1	0.9	27.2	94.9	6.3179	56.7192
2025	11	2	19	40	0	12	0.1	0.9	26.44	93	6.3179	55.2542
2025	11	2	19	50	0	12	0.1	0.9	26.98	94.5	6.3179	56.3007
2025	11	2	20	0	0	12	0.1	0.9	26.49	94.8	6.3179	55.2542
2025	11	2	20	10	0	12	0.1	0.9	27.12	92.1	6.3179	56.7193
2025	11	2	20	20	0	12	0.1	0.9	27.39	94.6	6.3179	57.1379
2025	11	2	20	30	0	12	0.1	0.9	26.97	94.3	6.3179	56.3008
2025	11	2	20	40	0	12	0.1	0.9	27.17	94.2	6.3179	56.7194
2025	11	2	20	50	0	12	0.1	0.9	26.44	93.3	6.3179	55.2544
2025	11	2	21	0	0	12	0.1	0.9	27.58	94.4	6.3179	57.5567
2025	11	2	21	10	0	12	0.1	0.9	26.04	93.1	6.3179	54.4172
2025	11	2	21	20	0	12	0.1	0.9	26.84	93.2	6.3179	56.0917
2025	11	2	21	30	0	12	0.1	0.9	26.7	94.9	6.3179	55.6731
2025	11	2	21	40	0	12	0.1	0.9	26.87	94.3	6.3179	56.0917
2025	11	2	21	50	0	12	0.1	0.9	26.77	94.1	6.3179	55.8824
2025	11	2	22	0	0	12	0.1	0.9	26.75	93.6	6.3179	55.8825
2025	11	2	22	10	0	12	0.1	0.9	26.98	94.5	6.324	56.3578
2025	11	2	22	20	0	12	0.1	0.9	27.35	93.4	6.324	57.1958
2025	11	2	22	30	0	12	0.1	0.9	27.66	96.2	6.324	57.6149
2025	11	2	22	40	0	12	0.1	0.9	25.66	94	6.324	53.6342
2025	11	2	22	50	0	12	0.1	0.9	26.52	92.4	6.324	55.5198
2025	11	2	23	0	0	12	0.1	0.9	27.17	94	6.3301	56.834
2025	11	2	23	10	0	12	0.1	0.9	27.01	91.3	6.3301	56.6243
2025	11	2	23	20	0	11.2	0.1	0.9	26.38	94.3	6.3301	55.1563
2025	11	2	23	30	0	11.2	0.1	0.9	26.59	94.7	6.3301	55.5758
2025	11	2	23	40	0	11.2	0.1	0.9	26.75	93.6	6.3301	55.9953
2025	11	2	23	50	0	11.2	0.1	0.9	27.18	94.4	6.3301	56.8342

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	3	0	0	0	11.2	0.1	0.9	26.97	94.3	6.3301	56.4148
2025	11	3	0	10	0	11.2	0.1	0.9	26.14	93.3	6.3301	54.737
2025	11	3	0	20	0	11.4	0.1	0.9	26.98	94.5	6.3301	56.4148
2025	11	3	0	30	0	11.4	0.1	0.9	26.16	93.7	6.3301	54.7371
2025	11	3	0	40	0	11.4	0.1	0.9	26.32	92	6.3301	55.1566
2025	11	3	0	50	0	11.4	0.1	0.9	26.43	92.6	6.3301	55.3663
2025	11	3	1	0	0	11.4	0.1	0.9	25.4	91.1	6.3301	53.2691
2025	11	3	1	10	0	11.4	0.1	0.9	26.23	92.6	6.3301	54.9469
2025	11	3	1	20	0	12	0.1	0.9	27.28	94.4	6.3301	57.0442
2025	11	3	1	30	0	12	0.1	0.9	27.85	96	6.3301	58.0928
2025	11	3	1	40	0	12	0.1	0.9	26.54	93.2	6.3301	55.5762
2025	11	3	1	50	0	12	0.1	0.9	26.76	93.9	6.3301	55.9956
2025	11	3	2	0	0	11.8	0.1	0.9	26.65	93.4	6.3301	55.786
2025	11	3	2	10	0	11.8	0.1	0.9	26.87	94.1	6.3301	56.2054
2025	11	3	2	20	0	11.8	0.1	0.9	26.92	91.9	6.3301	56.4152
2025	11	3	2	30	0	11.8	0.1	0.9	27.19	94.6	6.3301	56.8346
2025	11	3	2	40	0	11.8	0.1	0.9	26.58	96.7	6.3301	55.3666
2025	11	3	2	50	0	11.8	0.1	0.9	26.44	93	6.3301	55.3666
2025	11	3	3	0	0	11.8	0.1	0.9	26.13	95.7	6.3301	54.5278
2025	11	3	3	10	0	11.8	0.1	0.9	26.41	95.2	6.3301	55.157
2025	11	3	3	20	0	11.8	0.1	0.9	26.12	92.4	6.3301	54.7375
2025	11	3	3	30	0	11.8	0.1	0.9	26.03	92.9	6.3301	54.5278
2025	11	3	3	40	0	11.8	0.1	0.9	25.84	93.1	6.3301	54.1084
2025	11	3	3	50	0	11.8	0.1	0.9	27.55	93.5	6.3301	57.6737
2025	11	3	4	0	0	11.8	0.1	0.9	26.58	94.3	6.3301	55.5765
2025	11	3	4	10	0	11.8	0.1	0.9	26.48	94.5	6.3301	55.3668
2025	11	3	4	20	0	11.8	0.1	0.9	26.05	93.5	6.3301	54.5279
2025	11	3	4	30	0	11.8	0.1	0.9	26.69	94.7	6.3301	55.7863
2025	11	3	4	40	0	11.8	0.1	0.9	27.51	95.2	6.3301	57.464
2025	11	3	4	50	0	11.8	0.1	0.9	26.35	93.5	6.3301	55.1571
2025	11	3	5	0	0	11.8	0.1	0.9	26.42	95.4	6.3301	55.1571
2025	11	3	5	10	0	11.8	0.1	0.9	27.85	93.5	6.3301	58.303
2025	11	3	5	20	0	11.8	0.1	0.9	26.51	95.2	6.3301	55.3669
2025	11	3	5	30	0	11.8	0.1	0.9	27.32	95.5	6.3301	57.0447
2025	11	3	5	40	0	11.8	0.1	0.9	27.07	94.2	6.3301	56.6252
2025	11	3	5	50	0	11.8	0.1	0.9	26.95	93.4	6.3301	56.4155
2025	11	3	6	0	0	11.8	0.1	0.9	28.21	95.1	6.3301	58.9322
2025	11	3	6	10	0	11.8	0.1	0.9	26.95	93.6	6.3301	56.4156
2025	11	3	6	20	0	11.8	0.1	0.9	27.19	94.6	6.3301	56.835
2025	11	3	6	30	0	11.8	0.1	0.9	26.43	95.6	6.3301	55.1573
2025	11	3	6	40	0	11.8	0.1	0.9	27.22	95.5	6.3301	56.8351
2025	11	3	6	50	0	11.8	0.1	0.9	25.45	93.6	6.3301	53.2698
2025	11	3	7	0	0	11.8	0.1	0.9	26.45	93.7	6.324	55.3114
2025	11	3	7	10	0	11.8	0.1	0.9	26.54	95.8	6.3301	55.3671
2025	11	3	7	20	0	11.8	0.1	0.9	25.85	96.2	6.324	53.8449
2025	11	3	7	30	0	11.8	0.1	0.9	26.57	96.5	6.3301	55.3671
2025	11	3	7	40	0	11.6	0.1	0.9	26.14	93.1	6.324	54.6829
2025	11	3	7	50	0	11.6	0.1	0.9	27.12	95.3	6.3301	56.6255

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	3	8	0	0	11.6	0.1	0.9	27.3	96.9	6.3301	56.8352
2025	11	3	8	10	0	12	0.1	0.9	26.55	93.7	6.3301	55.5769
2025	11	3	8	20	0	12.6	0.1	0.9	26.34	93.3	6.3301	55.1574
2025	11	3	8	30	0	12.8	0.1	0.9	25.82	95.6	6.3301	53.8991
2025	11	3	8	40	0	13	0.1	0.9	26.6	95	6.3301	55.5769
2025	11	3	8	50	0	13	0.1	0.9	26.26	96.3	6.3301	54.738
2025	11	3	9	0	0	13.2	0.1	0.9	25.84	96	6.3301	53.8991
2025	11	3	9	10	0	13.2	0.1	0.9	26.1	95.1	6.3301	54.5283
2025	11	3	9	20	0	13.2	0.1	0.9	26.13	95.7	6.3301	54.5282
2025	11	3	9	30	0	13.4	0.1	0.9	25.08	94.6	6.3301	52.431
2025	11	3	9	40	0	13.6	0.1	0.9	25.19	94.8	6.3301	52.6407
2025	11	3	9	50	0	13.8	0.1	0.9	25.54	96.1	6.3301	53.2698
2025	11	3	10	0	0	13.8	0.1	0.9	28.02	95.3	6.3301	58.5129
2025	11	3	10	10	0	14.2	0.1	0.9	25.86	93.8	6.3301	54.1087
2025	11	3	10	20	0	14.2	0.1	0.9	26.21	95.3	6.3301	54.7378
2025	11	3	10	30	0	14	0.1	0.9	26.04	96	6.3301	54.3183
2025	11	3	10	40	0	14	0.1	0.9	25.59	94.7	6.3301	53.4794
2025	11	3	10	50	0	14.2	0.1	0.9	25.11	95.5	6.3301	52.4307
2025	11	3	11	0	0	14.2	0.1	0.9	25.42	95.6	6.3301	53.0599
2025	11	3	11	10	0	14.2	0.1	0.9	25.36	96.3	6.3301	52.8501
2025	11	3	11	20	0	14.2	0.1	0.9	25.64	93.4	6.3301	53.689
2025	11	3	11	30	0	14.2	0.1	0.9	25.17	94.3	6.3301	52.6403
2025	11	3	11	40	0	14.2	0.1	0.9	26.85	93.6	6.3301	56.2055
2025	11	3	11	50	0	14.2	0.1	0.9	26.68	96.7	6.3301	55.5763
2025	11	3	12	0	0	14.2	0.1	0.9	26.74	95.8	6.3301	55.786
2025	11	3	12	10	0	14	0.1	0.9	26.5	95	6.3301	55.3665
2025	11	3	12	20	0	14	0.1	0.9	27.34	93.1	6.3301	57.2539
2025	11	3	12	30	0	14	0.1	0.9	26.69	96.9	6.3301	55.5761
2025	11	3	12	40	0	14	0.1	0.9	27.41	95	6.3301	57.2538
2025	11	3	12	50	0	13.8	0.1	0.9	25.89	94.9	6.3301	54.1079
2025	11	3	13	0	0	13.8	0.1	0.9	25.79	94.7	6.3301	53.8981
2025	11	3	13	10	0	13.8	0.1	0.9	26.66	96.2	6.3301	55.5759
2025	11	3	13	20	0	13.8	0.1	0.9	26.84	95.8	6.324	55.939
2025	11	3	13	30	0	13.6	0.1	0.9	26.66	96.2	6.324	55.5199
2025	11	3	13	40	0	13.8	0.1	0.9	27.25	96.1	6.3179	56.7198
2025	11	3	13	50	0	13.8	0.1	0.9	26.76	97.9	6.324	55.5198
2025	11	3	14	0	0	13.8	0.1	0.9	26.02	92	6.3179	54.4175
2025	11	3	14	10	0	13.8	0.1	0.9	26.62	95.4	6.3179	55.4639
2025	11	3	14	20	0	13.4	0.1	0.9	26.87	98.1	6.3179	55.6732
2025	11	3	14	30	0	13.4	0.1	0.9	25.96	93.8	6.3179	54.208
2025	11	3	14	40	0	13.4	0.1	0.9	26.63	95.6	6.3179	55.4638
2025	11	3	14	50	0	13.4	0.1	0.9	26.11	97.3	6.3179	54.208
2025	11	3	15	0	0	13.4	0.1	0.9	27.07	94	6.3179	56.5102
2025	11	3	15	10	0	13.6	0.1	0.9	26.7	94.9	6.3179	55.673
2025	11	3	15	20	0	13.6	0.1	0.9	26.49	94.8	6.3179	55.2544
2025	11	3	15	30	0	13.6	0.1	0.9	25.74	93.1	6.3179	53.7892
2025	11	3	15	40	0	13.4	0.1	0.9	26.75	93.4	6.324	55.9384
2025	11	3	15	50	0	13.4	0.1	0.9	26.03	95.7	6.3179	54.2078

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	3	16	0	0	13.4	0.1	0.9	25.84	93.3	6.3179	53.9985
2025	11	3	16	10	0	13.4	0.1	0.9	25.79	94.9	6.3179	53.7892
2025	11	3	16	20	0	13.4	0.1	0.9	25.97	94.2	6.3179	54.2077
2025	11	3	16	30	0	13	0.1	0.9	26.98	96.6	6.3118	56.0349
2025	11	3	16	40	0	12.6	0.1	0.9	24.77	94.2	6.3179	51.6962
2025	11	3	16	50	0	13.4	0.1	0.9	25.98	94.6	6.3179	54.2077
2025	11	3	17	0	0	12.4	0.1	0.9	26.18	94.4	6.3179	54.6263
2025	11	3	17	10	0	11.8	0.1	0.9	26.03	95.7	6.3179	54.2077
2025	11	3	17	20	0	12.2	0.1	0.9	26.2	95	6.3179	54.6263
2025	11	3	17	30	0	12.2	0.1	0.9	26.4	95	6.3179	55.0448
2025	11	3	17	40	0	12.2	0.1	0.9	26.53	95.6	6.3179	55.2541
2025	11	3	17	50	0	12.2	0.1	0.9	25.79	94.9	6.3179	53.7891
2025	11	3	18	0	0	12.2	0.1	0.9	25.56	94	6.3179	53.3705
2025	11	3	18	10	0	12.2	0.1	0.9	26.42	92.4	6.3179	55.2541
2025	11	3	18	20	0	12.2	0.1	0.9	25.89	94.7	6.3179	53.9984
2025	11	3	18	30	0	12.2	0.1	0.9	25.79	94.9	6.3179	53.7891
2025	11	3	18	40	0	12.2	0.1	0.9	25.96	93.8	6.3179	54.2077
2025	11	3	18	50	0	12.2	0.1	0.9	26.26	96.3	6.3179	54.6263
2025	11	3	19	0	0	12.2	0.1	0.9	27.66	96.2	6.3179	57.5564
2025	11	3	19	10	0	12.2	0.1	0.9	26.48	94.5	6.3179	55.2542
2025	11	3	19	20	0	12.2	0.1	0.9	26.58	94.5	6.3179	55.4635
2025	11	3	19	30	0	12	0.1	0.9	25.88	94.4	6.3179	53.9985
2025	11	3	19	40	0	12	0.1	0.9	26.47	94.1	6.3179	55.2543
2025	11	3	19	50	0	12	0.1	0.9	25.12	92.1	6.3179	52.5334
2025	11	3	20	0	0	12	0.1	0.9	26.63	92.8	6.3179	55.6729
2025	11	3	20	10	0	12	0.1	0.9	27.63	95.6	6.3179	57.5566
2025	11	3	20	20	0	12	0.1	0.9	25.95	93.5	6.3179	54.2079
2025	11	3	20	30	0	12	0.1	0.9	26.44	93	6.3118	55.1988
2025	11	3	20	40	0	12	0.1	0.9	27.05	93.6	6.3179	56.5102
2025	11	3	20	50	0	12	0.1	0.9	26.63	95.6	6.3179	55.4638
2025	11	3	21	0	0	12	0.1	0.9	26.77	94.1	6.3118	55.8261
2025	11	3	21	10	0	12	0.1	0.9	26.52	95.4	6.3179	55.2545
2025	11	3	21	20	0	12	0.1	0.9	26.44	93	6.3118	55.1989
2025	11	3	21	30	0	12	0.1	0.9	26.34	93.3	6.3118	54.9899
2025	11	3	21	40	0	12	0.1	0.9	25.23	95.9	6.3118	52.4808
2025	11	3	21	50	0	12	0.1	0.9	26.47	96.5	6.3118	54.9899
2025	11	3	22	0	0	12	0.1	0.9	26.57	96.5	6.3118	55.199
2025	11	3	22	10	0	12	0.1	0.9	25.59	94.7	6.3118	53.3173
2025	11	3	22	20	0	12	0.1	0.9	27.17	96.3	6.3118	56.4536
2025	11	3	22	30	0	12	0.1	0.9	27.15	93.6	6.3118	56.6627
2025	11	3	22	40	0	12	0.1	0.9	25.48	94.5	6.3118	53.1082
2025	11	3	22	50	0	12	0.1	0.9	26.32	92.2	6.3118	54.9901
2025	11	3	23	0	0	12	0.1	0.9	25.63	92.9	6.3118	53.5265
2025	11	3	23	10	0	12	0.1	0.9	26.85	93.4	6.3118	56.0356
2025	11	3	23	20	0	12	0.1	0.9	26.25	93.5	6.3118	54.7811
2025	11	3	23	30	0	12	0.1	0.9	25.83	92.9	6.3179	53.9991
2025	11	3	23	40	0	12	0.1	0.9	26.88	94.5	6.3179	56.0921
2025	11	3	23	50	0	12	0.1	0.9	27.8	94.7	6.3179	57.9758

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	4	0	0	0	12	0.1	0.9	26.44	93.3	6.3179	55.2549
2025	11	4	0	10	0	12	0.1	0.9	26.59	94.7	6.3179	55.4643
2025	11	4	0	20	0	12	0.1	0.9	26.16	93.9	6.324	54.6821
2025	11	4	0	30	0	12	0.1	0.9	27.15	93.6	6.324	56.7772
2025	11	4	0	40	0	12	0.1	0.9	28	94.9	6.324	58.4533
2025	11	4	0	50	0	12	0.1	0.9	27.05	93.6	6.324	56.5678
2025	11	4	1	0	0	12	0.1	0.9	26.85	93.6	6.324	56.1488
2025	11	4	1	10	0	12	0.1	0.9	27.08	94.4	6.324	56.5678
2025	11	4	1	20	0	12	0.1	0.9	26.12	95.5	6.324	54.4728
2025	11	4	1	30	0	12	0.1	0.9	26.19	94.8	6.324	54.6823
2025	11	4	1	40	0	12	0.1	0.9	26.66	96.2	6.324	55.5204
2025	11	4	1	50	0	12	0.1	0.9	27.45	93.6	6.324	57.406
2025	11	4	2	0	0	12	0.1	0.9	26.44	93.3	6.324	55.3109
2025	11	4	2	10	0	11.8	0.1	0.9	26.73	92.8	6.324	55.9395
2025	11	4	2	20	0	11.8	0.1	0.9	27.38	96.5	6.324	56.9871
2025	11	4	2	30	0	11.8	0.1	0.9	26.18	94.6	6.324	54.6825
2025	11	4	2	40	0	11.8	0.1	0.9	26.84	93.2	6.324	56.1491
2025	11	4	2	50	0	11.8	0.1	0.9	27.34	95.9	6.324	56.9871
2025	11	4	3	0	0	11.8	0.1	0.9	27.68	94.4	6.324	57.8252
2025	11	4	3	10	0	11.8	0.1	0.9	27.04	93.2	6.324	56.5682
2025	11	4	3	20	0	11.8	0.1	0.9	26.83	92.8	6.324	56.1492
2025	11	4	3	30	0	11.8	0.1	0.9	25.93	92.9	6.324	54.2636
2025	11	4	3	40	0	11.8	0.1	0.9	27.51	95.2	6.324	57.4063
2025	11	4	3	50	0	11.8	0.1	0.9	27.14	93	6.324	56.7777
2025	11	4	4	0	0	11.8	0.1	0.9	26.1	95.1	6.324	54.4731
2025	11	4	4	10	0	11.8	0.1	0.9	26.38	94.3	6.324	55.1017
2025	11	4	4	20	0	11.8	0.1	0.9	27.19	94.6	6.3179	56.7207
2025	11	4	4	30	0	11.8	0.1	0.9	27.26	93.8	6.324	56.9873
2025	11	4	4	40	0	11.8	0.1	0.9	26.41	95.2	6.324	55.1017
2025	11	4	4	50	0	11.8	0.1	0.9	26.44	95.9	6.324	55.1017
2025	11	4	5	0	0	11.8	0.1	0.9	25.63	92.9	6.324	53.6352
2025	11	4	5	10	0	11.8	0.1	0.9	27.63	92.7	6.324	57.8254
2025	11	4	5	20	0	11.8	0.1	0.9	27.25	96.1	6.324	56.7779
2025	11	4	5	30	0	11.8	0.1	0.9	26.58	94.3	6.324	55.5208
2025	11	4	5	40	0	11.8	0.1	0.9	26.67	94.1	6.324	55.7304
2025	11	4	5	50	0	11.8	0.1	0.9	27.18	94.4	6.3179	56.7208
2025	11	4	6	0	0	11.8	0.1	0.9	26.74	93.2	6.3179	55.8837
2025	11	4	6	10	0	11.8	0.1	0.9	26.35	93.7	6.324	55.1019
2025	11	4	6	20	0	11.8	0.1	0.9	26.46	96.3	6.324	55.1019
2025	11	4	6	30	0	11.8	0.1	0.9	26.38	94.6	6.3179	55.0465
2025	11	4	6	40	0	11.8	0.1	0.9	27.22	95.3	6.3179	56.7209
2025	11	4	6	50	0	11.8	0.1	0.9	26.95	93.4	6.3179	56.3023
2025	11	4	7	0	0	11.8	0.1	0.9	26.88	94.5	6.3179	56.093
2025	11	4	7	10	0	11.8	0.1	0.9	26.86	93.8	6.3179	56.0931
2025	11	4	7	20	0	11.8	0.1	0.9	26.66	93.9	6.3179	55.6745
2025	11	4	7	30	0	11.8	0.1	0.9	26.95	93.6	6.324	56.3591
2025	11	4	7	40	0	11.8	0.1	0.9	26.64	93.2	6.324	55.7305
2025	11	4	7	50	0	11.8	0.1	0.9	27.57	94	6.324	57.6162

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	4	8	0	0	11.8	0.1	0.9	26.58	94.3	6.324	55.5211
2025	11	4	8	10	0	12	0.1	0.9	26.27	96.6	6.324	54.683
2025	11	4	8	20	0	12.6	0.1	0.9	26.83	92.8	6.324	56.1496
2025	11	4	8	30	0	12.8	0.1	0.9	26.02	95.5	6.324	54.264
2025	11	4	8	40	0	13	0.1	0.9	26.23	92.8	6.324	54.8926
2025	11	4	8	50	0	13	0.1	0.9	27.14	93.2	6.324	56.7782
2025	11	4	9	0	0	13.2	0.1	0.9	26.16	93.7	6.324	54.6831
2025	11	4	9	10	0	13.2	0.1	0.9	25.88	94.4	6.324	54.0545
2025	11	4	9	20	0	13.2	0.1	0.9	27.12	95.3	6.324	56.5686
2025	11	4	9	30	0	13.4	0.1	0.9	24.92	92.1	6.324	52.1689
2025	11	4	9	40	0	13.6	0.1	0.9	26.99	94.7	6.324	56.3591
2025	11	4	9	50	0	13.8	0.1	0.9	26.37	96.5	6.324	54.8925
2025	11	4	10	0	0	14.2	0.1	0.9	27.23	92.7	6.324	56.9876
2025	11	4	10	10	0	14.2	0.1	0.9	26.26	93.7	6.324	54.8924
2025	11	4	10	20	0	14.2	0.1	0.9	26.11	91.8	6.324	54.6829
2025	11	4	10	30	0	14.2	0.1	0.9	26.68	94.5	6.324	55.7304
2025	11	4	10	40	0	14	0.1	0.9	26.99	94.7	6.3301	56.4156
2025	11	4	10	50	0	14	0.1	0.9	25.89	94.7	6.3301	54.1086
2025	11	4	11	0	0	14	0.1	0.9	27.29	94.6	6.3301	57.0447
2025	11	4	11	10	0	14.2	0.1	0.9	26.41	95.2	6.3301	55.1571
2025	11	4	11	20	0	14	0.1	0.9	26.54	95.8	6.3301	55.3668
2025	11	4	11	30	0	14.2	0.1	0.9	26.53	95.6	6.3301	55.3668
2025	11	4	11	40	0	14.2	0.1	0.9	26.84	93.2	6.3301	56.2056
2025	11	4	11	50	0	14.2	0.1	0.9	25.99	94.9	6.3301	54.318
2025	11	4	12	0	0	14.2	0.1	0.9	25.8	98.7	6.3301	53.4791
2025	11	4	12	10	0	14.2	0.1	0.9	26.13	95.7	6.3301	54.5277
2025	11	4	12	20	0	13.4	0.1	0.9	27.03	97.4	6.3301	56.2054
2025	11	4	12	30	0	13.4	0.1	0.9	26.83	97.5	6.3301	55.7859
2025	11	4	12	40	0	13.4	0.1	0.9	26.67	96.5	6.3301	55.5761
2025	11	4	12	50	0	13.4	0.1	0.9	27.07	94.2	6.3301	56.6246
2025	11	4	13	0	0	13.4	0.1	0.9	27.38	96.5	6.3301	57.0441
2025	11	4	13	10	0	13.4	0.1	0.9	27.16	96.1	6.3301	56.6246
2025	11	4	13	20	0	13.4	0.1	0.9	26.7	94.9	6.3301	55.7856
2025	11	4	13	30	0	13.4	0.1	0.9	26.85	96	6.3362	56.0515
2025	11	4	13	40	0	13.4	0.1	0.9	27.57	96.5	6.3301	57.4633
2025	11	4	13	50	0	13.4	0.1	0.9	25.78	96.7	6.3301	53.6883
2025	11	4	14	0	0	13.4	0.1	0.9	26.12	97.5	6.3301	54.3174
2025	11	4	14	10	0	13.4	0.1	0.9	26.97	96.4	6.3301	56.2048
2025	11	4	14	20	0	13.4	0.1	0.9	26.11	95.3	6.3362	54.5818
2025	11	4	14	30	0	13.4	0.1	0.9	26.77	96.4	6.3362	55.8414
2025	11	4	14	40	0	13.4	0.1	0.9	26.35	93.7	6.3301	55.1561
2025	11	4	14	50	0	13.4	0.1	0.9	26.56	98	6.3362	55.2115
2025	11	4	15	0	0	13.4	0.1	0.9	27.12	95.3	6.3362	56.681
2025	11	4	15	10	0	13.4	0.1	0.9	26.89	96.8	6.3423	56.1074
2025	11	4	15	20	0	13.4	0.1	0.9	24.94	96	6.3423	52.1147
2025	11	4	15	30	0	13.4	0.1	0.9	26.58	96.7	6.3423	55.4769
2025	11	4	15	40	0	13.2	0.1	0.9	27.05	93.4	6.3423	56.7377
2025	11	4	15	50	0	13.2	0.1	0.9	26.45	96.1	6.3423	55.2668

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	4	16	0	0	13.2	0.1	0.9	26.8	97.1	6.3484	55.9532
2025	11	4	16	10	0	13.2	0.1	0.9	27.17	94.2	6.3423	56.9478
2025	11	4	16	20	0	13.2	0.1	0.9	26.04	96	6.3484	54.4807
2025	11	4	16	30	0	13.2	0.1	0.9	26.2	97	6.3484	54.691
2025	11	4	16	40	0	13.4	0.1	0.9	26.26	98.1	6.3484	54.691
2025	11	4	16	50	0	13.4	0.1	0.9	27.11	97.2	6.3484	56.5842
2025	11	4	17	0	0	13.4	0.1	0.9	25.65	93.6	6.3484	53.8496
2025	11	4	17	10	0	12.4	0.1	0.9	27.57	96.5	6.3484	57.6359
2025	11	4	17	20	0	12.2	0.1	0.9	27.18	94.4	6.3545	57.0619
2025	11	4	17	30	0	12.2	0.1	0.9	26.78	94.5	6.3545	56.2197
2025	11	4	17	40	0	12.2	0.1	0.9	27.18	94.4	6.3606	57.119
2025	11	4	17	50	0	12.2	0.1	0.9	27.34	92.9	6.3606	57.5406
2025	11	4	18	0	0	12.2	0.1	0.9	26.63	92.6	6.3606	56.0652
2025	11	4	18	10	0	12.2	0.1	0.9	28.65	93.4	6.3606	60.2806
2025	11	4	18	20	0	12.2	0.1	0.9	27.27	94	6.3606	57.3298
2025	11	4	18	30	0	12.2	0.1	0.9	27.48	94.4	6.3606	57.7514
2025	11	4	18	40	0	12.2	0.1	0.9	26.55	93.7	6.3606	55.8544
2025	11	4	18	50	0	12.2	0.1	0.9	26.97	94.3	6.3667	56.7542
2025	11	4	19	0	0	12.2	0.1	0.9	27.77	93.9	6.3667	58.4421
2025	11	4	19	10	0	12.2	0.1	0.9	26.64	93.2	6.3667	56.1213
2025	11	4	19	20	0	12.2	0.1	0.9	27.12	95.5	6.3667	56.9652
2025	11	4	19	30	0	12.2	0.1	0.9	26.72	92.4	6.3667	56.3323
2025	11	4	19	40	0	12	0.1	0.9	26.75	93.6	6.3667	56.3323
2025	11	4	19	50	0	12	0.1	0.9	27.05	93.4	6.3667	56.9653
2025	11	4	20	0	0	12	0.1	0.9	28.05	93.5	6.3667	59.0752
2025	11	4	20	10	0	12	0.1	0.9	26.85	93.6	6.3667	56.5434
2025	11	4	20	20	0	12	0.1	0.9	27.71	95.2	6.3667	58.2313
2025	11	4	20	30	0	12	0.1	0.9	27.7	95	6.3667	58.2313
2025	11	4	20	40	0	12	0.1	0.9	26.84	93	6.3667	56.5435
2025	11	4	20	50	0	12	0.1	0.9	26.82	92.1	6.3667	56.5435
2025	11	4	21	0	0	12	0.1	0.9	27.22	92.1	6.3667	57.3875
2025	11	4	21	10	0	12	0.1	0.9	27.76	96.2	6.3667	58.2314
2025	11	4	21	20	0	12	0.1	0.9	27.69	94.6	6.3667	58.2315
2025	11	4	21	30	0	12	0.1	0.9	27.45	93.6	6.3667	57.8095
2025	11	4	21	40	0	12	0.1	0.9	26.63	92.6	6.3667	56.1217
2025	11	4	21	50	0	12	0.1	0.9	27.58	94.4	6.3667	58.0206
2025	11	4	22	0	0	12	0.1	0.9	26.74	93.2	6.3728	56.389
2025	11	4	22	10	0	12	0.1	0.9	25.87	94.2	6.3728	54.4883
2025	11	4	22	20	0	12	0.1	0.9	27.11	91.9	6.3728	57.2338
2025	11	4	22	30	0	12	0.1	0.9	27.48	94.4	6.3728	57.8674
2025	11	4	22	40	0	12	0.1	0.9	27.52	92.3	6.3728	58.0787
2025	11	4	22	50	0	12	0.1	0.9	27.17	94	6.3728	57.2339
2025	11	4	23	0	0	12	0.1	0.9	26.62	95.4	6.3728	55.9668
2025	11	4	23	10	0	12	0.1	0.9	26.97	94.3	6.3728	56.8116
2025	11	4	23	20	0	12	0.1	0.9	27.87	94.1	6.3728	58.7124
2025	11	4	23	30	0	12	0.1	0.9	27.98	94.3	6.3728	58.9236
2025	11	4	23	40	0	12	0.1	0.9	26.22	92.2	6.3728	55.3333
2025	11	4	23	50	0	12	0.1	0.9	27.18	94.4	6.3728	57.2341

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	5	0	0	0	12	0.1	0.9	28.62	95.2	6.3728	60.1909
2025	11	5	0	10	0	12	0.1	1	26.78	94.5	6.3789	56.4456
2025	11	5	0	20	0	12	0.1	1	27.75	93.5	6.385	58.6181
2025	11	5	0	30	0	12	0.1	1	27.86	93.7	6.385	58.8297
2025	11	5	0	40	0	12	0.1	1	27.45	93.6	6.391	58.041
2025	11	5	0	50	0	12	0.1	1	27.49	94.6	6.391	58.041
2025	11	5	1	0	0	12	0.1	1	27.14	93	6.391	57.4056
2025	11	5	1	10	0	12	0.1	1	26.5	95	6.3971	55.9784
2025	11	5	1	20	0	12	0.1	1	25.93	92.7	6.3971	54.9183
2025	11	5	1	30	0	12	0.1	1	27.4	94.8	6.3971	57.8868
2025	11	5	1	40	0	12	0.1	1	26.44	93.3	6.3971	55.9785
2025	11	5	1	50	0	12	0.1	1	26.43	92.6	6.3971	55.9785
2025	11	5	2	0	0	12	0.1	1	27.86	93.7	6.3971	58.9471
2025	11	5	2	10	0	12	0.1	1	26.42	92	6.4032	56.0342
2025	11	5	2	20	0	12	0.1	1	27.74	92.9	6.4032	58.7935
2025	11	5	2	30	0	12	0.1	1	27.06	96.2	6.3971	57.0388
2025	11	5	2	40	0	11.8	0.1	1	26.45	93.5	6.4032	56.0343
2025	11	5	2	50	0	11.8	0.1	1	26.83	92.8	6.4032	56.8833
2025	11	5	3	0	0	11.8	0.1	1	27.22	92.3	6.4032	57.7323
2025	11	5	3	10	0	11.8	0.1	1	27.87	94.1	6.4032	59.0059
2025	11	5	3	20	0	11.8	0.1	1	27.29	94.6	6.4032	57.7324
2025	11	5	3	30	0	11.8	0.1	1	27.83	92.5	6.4032	59.0059
2025	11	5	3	40	0	11.8	0.1	1	26.41	95.2	6.4032	55.8222
2025	11	5	3	50	0	11.8	0.1	1	26.95	93.6	6.4032	57.0957
2025	11	5	4	0	0	11.8	0.1	1	27.7	94.8	6.4032	58.5814
2025	11	5	4	10	0	11.8	0.1	1	27.24	92.9	6.4032	57.7325
2025	11	5	4	20	0	11.8	0.1	1	27.14	93.2	6.4032	57.5202
2025	11	5	4	30	0	11.8	0.1	1	27.86	96.2	6.4032	58.7937
2025	11	5	4	40	0	11.8	0.1	1	26.63	95.6	6.4032	56.2467
2025	11	5	4	50	0	11.8	0.1	1	27.65	96	6.4032	58.3693
2025	11	5	5	0	0	11.8	0.1	1	26.75	93.6	6.4032	56.6713
2025	11	5	5	10	0	11.8	0.1	1	27.99	94.7	6.4032	59.2183
2025	11	5	5	20	0	11.8	0.1	1	27.6	95	6.4032	58.3693
2025	11	5	5	30	0	11.8	0.1	1	27.41	91.3	6.4032	58.1571
2025	11	5	5	40	0	11.8	0.1	1	27.86	93.7	6.4032	59.0061
2025	11	5	5	50	0	11.8	0.1	1	27.52	92.1	6.4032	58.3693
2025	11	5	6	0	0	11.8	0.1	1	27.47	94.2	6.4032	58.1571
2025	11	5	6	10	0	11.8	0.1	1	26.63	92.6	6.4032	56.4591
2025	11	5	6	20	0	11.8	0.1	1	27.43	92.7	6.4093	58.2149
2025	11	5	6	30	0	11.8	0.1	1	27.87	94.1	6.4032	59.0062
2025	11	5	6	40	0	11.8	0.1	1	27.21	91.7	6.4093	57.79
2025	11	5	6	50	0	11.8	0.1	1	27.89	94.5	6.4032	59.0062
2025	11	5	7	0	0	11.8	0.1	1	27.18	94.4	6.4032	57.5204
2025	11	5	7	10	0	11.8	0.1	1	27.59	94.6	6.4093	58.4274
2025	11	5	7	20	0	11.8	0.1	1	27.53	92.5	6.4093	58.4274
2025	11	5	7	30	0	11.8	0.1	1	27.6	95	6.4093	58.4274
2025	11	5	7	40	0	11.8	0.1	1	27.2	94.9	6.4093	57.5776
2025	11	5	7	50	0	11.8	0.1	1	28.27	94.1	6.4093	59.9147

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	5	8	0	0	11.8	0.1	1	26.85	93.6	6.4093	56.9402
2025	11	5	8	10	0	12	0.1	1	27.83	95.6	6.4093	58.8524
2025	11	5	8	20	0	12.4	0.1	1	27.61	95.2	6.4093	58.4275
2025	11	5	8	30	0	12.6	0.1	1	27.17	94.2	6.4093	57.5776
2025	11	5	8	40	0	12.8	0.1	1	26.93	92.6	6.4093	57.1527
2025	11	5	8	50	0	12.8	0.1	1	27.45	93.6	6.4093	58.215
2025	11	5	9	0	0	12.8	0.1	1	27.01	91.7	6.4093	57.3651
2025	11	5	9	10	0	13	0.1	1	27.56	96.2	6.4093	58.215
2025	11	5	9	20	0	13	0.1	1	27.05	93.6	6.4093	57.3651
2025	11	5	9	30	0	13	0.1	1	27.65	96	6.4093	58.4274
2025	11	5	9	40	0	13.2	0.1	1	28.04	95.7	6.4093	59.2772
2025	11	5	9	50	0	13.2	0.1	1	27.01	95.1	6.4093	57.1526
2025	11	5	10	0	0	13.4	0.1	1	26.23	92.8	6.4093	55.6653
2025	11	5	10	10	0	13.4	0.1	1	27.51	95.2	6.4093	58.2148
2025	11	5	10	20	0	13.4	0.1	1	26.04	93.3	6.4154	55.2951
2025	11	5	10	30	0	13.4	0.1	1	28.33	97.3	6.4154	59.7612
2025	11	5	10	40	0	13.4	0.1	1	27.22	95.5	6.4154	57.6344
2025	11	5	10	50	0	13.4	0.1	1	27.05	93.6	6.4154	57.4217
2025	11	5	11	0	0	13.4	0.1	1	26.4	95	6.4154	55.933
2025	11	5	11	10	0	13.4	0.1	1	26.4	95	6.4154	55.9329
2025	11	5	11	20	0	13.4	0.1	1	27.01	97.2	6.4154	56.9962
2025	11	5	11	30	0	13.4	0.1	1	27.79	94.5	6.4154	58.9102
2025	11	5	11	40	0	13.4	0.1	1	28.33	95.5	6.4215	60.033
2025	11	5	11	50	0	13.4	0.1	1	26.82	95.3	6.4215	56.8397
2025	11	5	12	0	0	13.4	0.1	1	26.51	95.2	6.4215	56.201
2025	11	5	12	10	0	13.4	0.1	1	27.21	97.2	6.4215	57.4782
2025	11	5	12	20	0	13.4	0.1	1	27.64	92.9	6.4215	58.7555
2025	11	5	12	30	0	13.4	0.1	1	27.86	96.2	6.4215	58.9683
2025	11	5	12	40	0	13.4	0.1	1	27.1	94.9	6.4215	57.4781
2025	11	5	12	50	0	13.4	0.1	1	27.62	95.4	6.4276	58.6004
2025	11	5	13	0	0	13.4	0.1	1	27.2	98.5	6.4215	57.2651
2025	11	5	13	10	0	13.4	0.1	1	27.46	96.3	6.4276	58.1741
2025	11	5	13	20	0	13.2	0.1	1	27	94.9	6.4276	57.3217
2025	11	5	13	30	0	13.4	0.1	1	26.88	96.6	6.4276	56.8954
2025	11	5	13	40	0	13.4	0.1	1	28.13	97.4	6.4337	59.5113
2025	11	5	13	50	0	13.4	0.1	1	26.25	96.1	6.4276	55.6168
2025	11	5	14	0	0	13.4	0.1	1	27.22	95.5	6.4337	57.8048
2025	11	5	14	10	0	13.4	0.1	1	28.03	92.7	6.4337	59.7244
2025	11	5	14	20	0	13.4	0.1	1	27.71	95.2	6.4276	58.813
2025	11	5	14	30	0	13.2	0.1	1	28.55	93.4	6.4337	60.7909
2025	11	5	14	40	0	13.2	0.1	1	26.59	94.7	6.4337	56.5248
2025	11	5	14	50	0	13.2	0.1	1	26.72	95.4	6.4337	56.7381
2025	11	5	15	0	0	13.2	0.1	1	29.14	95.7	6.4337	61.8572
2025	11	5	15	10	0	13.2	0.1	1	27.5	94.8	6.4337	58.4444
2025	11	5	15	20	0	13.2	0.1	1	27.38	94.4	6.4337	58.231
2025	11	5	15	30	0	13.2	0.1	1	27.6	95	6.4398	58.7156
2025	11	5	15	40	0	13.2	0.1	1	27.22	92.3	6.4398	58.075
2025	11	5	15	50	0	13.2	0.1	1	27.83	95.6	6.4398	59.1425

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	5	16	0	0	13.2	0.1	1	28.54	95.6	6.4398	60.6371
2025	11	5	16	10	0	13.2	0.1	1	26.63	95.6	6.4398	56.5803
2025	11	5	16	20	0	13.2	0.1	1	27.71	95.2	6.4398	58.9289
2025	11	5	16	30	0	13.4	0.1	1	28.01	95.1	6.4398	59.5694
2025	11	5	16	40	0	13.4	0.1	1	28.18	94.3	6.4398	59.9964
2025	11	5	16	50	0	12.8	0.1	1	27.24	92.9	6.4398	58.0748
2025	11	5	17	0	0	12.4	0.1	1	27.64	93.1	6.4398	58.9288
2025	11	5	17	10	0	12.4	0.1	1	28.43	92.6	6.4398	60.6369
2025	11	5	17	20	0	12.2	0.1	1	27.52	92.3	6.4398	58.7153
2025	11	5	17	30	0	12.2	0.1	1	27.87	94.1	6.4459	59.4144
2025	11	5	17	40	0	12.2	0.1	1	27.11	95.1	6.4459	57.7046
2025	11	5	17	50	0	12.2	0.1	1	28.17	94.1	6.4459	60.0555
2025	11	5	18	0	0	12.2	0.1	1	27.79	94.5	6.4459	59.2006
2025	11	5	18	10	0	12.2	0.1	1	27.8	95	6.4459	59.2006
2025	11	5	18	20	0	12.2	0.1	1	27.17	94.2	6.4459	57.9183
2025	11	5	18	30	0	12.2	0.1	1	28.23	92.8	6.4459	60.2692
2025	11	5	18	40	0	12.2	0.1	1	26.79	94.7	6.4459	57.0634
2025	11	5	18	50	0	12.2	0.1	1	27.48	94.4	6.452	58.6172
2025	11	5	19	0	0	12.2	0.1	1	28.22	92.2	6.452	60.3286
2025	11	5	19	10	0	12.2	0.1	1	26.93	92.8	6.4459	57.4909
2025	11	5	19	20	0	12.2	0.1	1	27.87	94.1	6.452	59.4729
2025	11	5	19	30	0	12.2	0.1	1	28.88	94.2	6.452	61.6123
2025	11	5	19	40	0	12.2	0.1	1	27.48	94.4	6.452	58.6172
2025	11	5	19	50	0	12.2	0.1	1	27.5	94.8	6.452	58.6172
2025	11	5	20	0	0	12.2	0.1	1	28.36	93.8	6.452	60.5426
2025	11	5	20	10	0	12.2	0.1	1	27.74	95.8	6.452	59.0451
2025	11	5	20	20	0	12.2	0.1	1	28.02	92.2	6.452	59.9008
2025	11	5	20	30	0	12.2	0.1	1	26.52	92.4	6.452	56.6919
2025	11	5	20	40	0	12.2	0.1	1	28.66	93.8	6.452	61.1845
2025	11	5	20	50	0	12.2	0.1	1	28	90.2	6.452	59.9009
2025	11	5	21	0	0	12.2	0.1	1	27.43	92.7	6.452	58.6173
2025	11	5	21	10	0	12	0.1	1	27.85	93.5	6.452	59.473
2025	11	5	21	20	0	12	0.1	1	28.23	92.6	6.452	60.3288
2025	11	5	21	30	0	12	0.1	1	28.29	94.5	6.452	60.3288
2025	11	5	21	40	0	12	0.1	1	28.15	93.5	6.4459	60.0556
2025	11	5	21	50	0	12	0.1	1	27.89	94.5	6.4459	59.4145
2025	11	5	22	0	0	12	0.1	1	27.6	95	6.452	58.8313
2025	11	5	22	10	0	12	0.1	1	27.8	95	6.4459	59.2008
2025	11	5	22	20	0	12	0.1	1	28.35	93.2	6.4459	60.4831
2025	11	5	22	30	0	12	0.1	1	28.73	92.6	6.452	61.3985
2025	11	5	22	40	0	12	0.1	1	27.7	94.8	6.452	59.0453
2025	11	5	22	50	0	12	0.1	1	27.96	93.7	6.4459	59.6283
2025	11	5	23	0	0	12	0.1	1	27.15	93.6	6.4459	57.9185
2025	11	5	23	10	0	12	0.1	1	28.45	93.4	6.4459	60.6969
2025	11	5	23	20	0	12	0.1	1	27.81	95.2	6.4459	59.2009
2025	11	5	23	30	0	12	0.1	1	27.78	94.3	6.452	59.2593
2025	11	5	23	40	0	12	0.1	1	26.66	93.9	6.452	56.906
2025	11	5	23	50	0	12	0.1	1	24.11	84.5	6.4581	51.3944

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	6	0	0	0	12	0.1	1	26.02	92	6.4581	55.6773
2025	11	6	0	10	0	12	0.1	1	26.77	94.1	6.4581	57.1763
2025	11	6	0	20	0	12	0.1	1	27.35	96.1	6.4581	58.247
2025	11	6	0	30	0	12	0.1	1	26.86	96.2	6.4642	57.2326
2025	11	6	0	40	0	12	0.1	1	26.33	92.8	6.4703	56.4306
2025	11	6	0	50	0	12	0.1	1	28.68	94.2	6.4703	61.3656
2025	11	6	1	0	0	12	0.1	1	28.03	92.7	6.4703	60.0782
2025	11	6	1	10	0	12	0.1	1	26.53	92.8	6.4764	56.9156
2025	11	6	1	20	0	12	0.1	1	27.88	94.3	6.4764	59.7077
2025	11	6	1	30	0	12	0.1	1	27.96	96.2	6.4825	59.7663
2025	11	6	1	40	0	12	0.1	1	27.13	92.7	6.4825	58.2614
2025	11	6	1	50	0	12	0.1	1	26.78	94.5	6.4825	57.4015
2025	11	6	2	0	0	12	0.1	1	27.67	93.9	6.4825	59.3364
2025	11	6	2	10	0	12	0.1	1	25.92	95.5	6.4825	55.4666
2025	11	6	2	20	0	12	0.1	1	26.4	95	6.4825	56.5416
2025	11	6	2	30	0	12	0.1	1	27.52	95.4	6.4886	58.9642
2025	11	6	2	40	0	12	0.1	1	27.38	94.4	6.4886	58.749
2025	11	6	2	50	0	12	0.1	1	27.39	94.6	6.4886	58.749
2025	11	6	3	0	0	12	0.1	1	27.39	94.6	6.4886	58.749
2025	11	6	3	10	0	12	0.1	1	27.7	95	6.4886	59.3946
2025	11	6	3	20	0	12	0.1	1	27.54	92.9	6.4886	59.1795
2025	11	6	3	30	0	12	0.1	1	27.81	95.2	6.4886	59.6099
2025	11	6	3	40	0	12	0.1	1	27.92	92.1	6.4886	60.0403
2025	11	6	3	50	0	12	0.1	1	28.53	92.6	6.4947	61.3915
2025	11	6	4	0	0	12	0.1	1	27.77	94.1	6.4947	59.6683
2025	11	6	4	10	0	12	0.1	1	28.08	94.3	6.4947	60.3145
2025	11	6	4	20	0	11.8	0.1	1	28.05	93.3	6.4947	60.3145
2025	11	6	4	30	0	11.8	0.1	1	27.75	93.5	6.4947	59.6683
2025	11	6	4	40	0	11.8	0.1	1	27.6	95	6.4947	59.2375
2025	11	6	4	50	0	11.8	0.1	1	28.09	94.7	6.4947	60.3146
2025	11	6	5	0	0	11.8	0.1	1	27.7	95	6.4947	59.4529
2025	11	6	5	10	0	11.8	0.1	1	27.57	94	6.4947	59.2376
2025	11	6	5	20	0	11.8	0.1	1	28.86	93.8	6.4947	62.0379
2025	11	6	5	30	0	11.8	0.1	1	26.72	92.4	6.4947	57.5143
2025	11	6	5	40	0	11.8	0.1	1	28.28	94.3	6.5008	60.8049
2025	11	6	5	50	0	11.8	0.1	1	26.91	91.5	6.5008	58.0018
2025	11	6	6	0	0	11.8	0.1	1	28.54	93	6.5008	61.4518
2025	11	6	6	10	0	11.8	0.1	1	28.54	93	6.5008	61.4518
2025	11	6	6	20	0	11.8	0.1	1	28.01	95.1	6.5008	60.1581
2025	11	6	6	30	0	11.8	0.1	1	28.27	94.1	6.5008	60.805
2025	11	6	6	40	0	11.8	0.1	1	27.89	94.5	6.5008	59.9425
2025	11	6	6	50	0	11.8	0.1	1	28.03	92.7	6.5008	60.3737
2025	11	6	7	0	0	11.8	0.1	1	28.49	94.4	6.5008	61.2362
2025	11	6	7	10	0	11.8	0.1	1	27.24	93.2	6.5008	58.6488
2025	11	6	7	20	0	11.8	0.1	1	27.9	94.9	6.5008	59.9426
2025	11	6	7	30	0	11.8	0.1	1	27.05	93.6	6.5008	58.2176
2025	11	6	7	40	0	11.8	0.1	1	26.71	91.5	6.5008	57.5708
2025	11	6	7	50	0	11.8	0.1	1	28.06	93.7	6.5008	60.3739

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	6	8	0	0	11.8	0.1	1	28.31	91.6	6.5008	61.0207
2025	11	6	8	10	0	11.8	0.1	1	28.02	92	6.5008	60.3739
2025	11	6	8	20	0	12.4	0.1	1	28.54	93	6.5008	61.452
2025	11	6	8	30	0	12.6	0.1	1	27.76	93.7	6.5008	59.7271
2025	11	6	8	40	0	12.8	0.1	1	27.98	94.3	6.5008	60.1583
2025	11	6	8	50	0	12.8	0.1	1	27.48	94.4	6.5008	59.0802
2025	11	6	9	0	0	13	0.1	1	27.83	92.7	6.5008	59.9427
2025	11	6	9	10	0	13	0.1	1	27.78	94.3	6.5008	59.7271
2025	11	6	9	20	0	13	0.1	1	28.25	93.4	6.5069	60.8646
2025	11	6	9	30	0	13	0.1	1	28.55	93.4	6.5069	61.5121
2025	11	6	9	40	0	13.2	0.1	1	28.23	92.8	6.5069	60.8646
2025	11	6	9	50	0	13.4	0.1	1	27.62	95.4	6.5069	59.3538
2025	11	6	10	0	0	13.6	0.1	1	27.98	94.3	6.5069	60.2171
2025	11	6	10	10	0	13.6	0.1	1	28.32	95.3	6.5069	60.8645
2025	11	6	10	20	0	13.4	0.1	1	28.11	91.6	6.5069	60.6487
2025	11	6	10	30	0	13.4	0.1	1	28.71	91.6	6.5069	61.9436
2025	11	6	10	40	0	13.4	0.1	1	27.96	93.7	6.5069	60.2169
2025	11	6	10	50	0	13.4	0.1	1	28.87	94	6.5069	62.1594
2025	11	6	11	0	0	13.4	0.1	1	28.03	95.5	6.5069	60.2169
2025	11	6	11	10	0	13.4	0.1	1	27.34	92.9	6.513	58.9794
2025	11	6	11	20	0	13.4	0.1	1	28.09	94.5	6.513	60.4917
2025	11	6	11	30	0	13.4	0.1	1	27.52	92.1	6.513	59.4114
2025	11	6	11	40	0	13.8	0.1	1	28.88	94.2	6.513	62.2199
2025	11	6	11	50	0	13.8	0.1	1	28.51	95	6.513	61.3557
2025	11	6	12	0	0	13.8	0.1	1	28.26	93.7	6.513	60.9236
2025	11	6	12	10	0	13.6	0.1	1	27.48	94.4	6.513	59.1952
2025	11	6	12	20	0	13.6	0.1	1	28.73	92.4	6.513	62.0037
2025	11	6	12	30	0	13.8	0.1	1	28.13	92.4	6.5191	60.7666
2025	11	6	12	40	0	13.8	0.1	1	27.93	92.7	6.5191	60.3341
2025	11	6	12	50	0	13.8	0.1	1	27.97	94.1	6.5191	60.334
2025	11	6	13	0	0	13.8	0.1	1	27.83	92.7	6.5191	60.1177
2025	11	6	13	10	0	13.8	0.1	1	27.79	94.5	6.5191	59.9014
2025	11	6	13	20	0	13.8	0.1	1	28.65	93.4	6.5191	61.8476
2025	11	6	13	30	0	13.8	0.1	1	27.95	93.5	6.5191	60.3338
2025	11	6	13	40	0	13.6	0.1	1	29.17	93.9	6.5191	62.9288
2025	11	6	13	50	0	13.6	0.1	1	27.6	91	6.5191	59.685
2025	11	6	14	0	0	13.4	0.1	1	27.82	95.4	6.5191	59.9012
2025	11	6	14	10	0	13.4	0.1	1	28.38	94.2	6.5252	61.2583
2025	11	6	14	20	0	13.4	0.1	1	28.21	95.1	6.5252	60.8254
2025	11	6	14	30	0	13.4	0.1	1	27.99	94.7	6.5252	60.3924
2025	11	6	14	40	0	13.4	0.1	1	28.08	94.3	6.5252	60.6088
2025	11	6	14	50	0	13.4	0.1	1	28.75	93.4	6.5252	62.124
2025	11	6	15	0	0	13.4	0.1	1	27.75	93.3	6.5252	59.9594
2025	11	6	15	10	0	13.4	0.1	1	27.37	94.2	6.5252	59.0935
2025	11	6	15	20	0	13.4	0.1	1	29.26	93.7	6.5252	63.2062
2025	11	6	15	30	0	13.2	0.1	1	28.08	94.3	6.5252	60.6087
2025	11	6	15	40	0	13.2	0.1	1	29.15	93.3	6.5252	62.9897
2025	11	6	15	50	0	13.2	0.1	1	27.89	94.7	6.5252	60.1757

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	6	16	0	0	13.2	0.1	1	29.34	92.9	6.5252	63.4226
2025	11	6	16	10	0	13.2	0.1	1	29.15	93.3	6.5252	62.9896
2025	11	6	16	20	0	13.2	0.1	1	28.54	93.2	6.5252	61.6908
2025	11	6	16	30	0	13.2	0.1	1	29.04	93.2	6.5252	62.7731
2025	11	6	16	40	0	13.2	0.1	1	29.23	95.5	6.5252	62.9896
2025	11	6	16	50	0	13.2	0.1	1	29.1	89.6	6.5252	62.9896
2025	11	6	17	0	0	13.2	0.1	1	29.01	91.6	6.5313	62.8342
2025	11	6	17	10	0	12.2	0.1	1	27.45	93.6	6.5313	59.3675
2025	11	6	17	20	0	12.2	0.1	1	29.42	95.3	6.5313	63.4842
2025	11	6	17	30	0	12.2	0.1	1	28.35	93.4	6.5313	61.3175
2025	11	6	17	40	0	12.2	0.1	1	28.85	95.8	6.5313	62.1842
2025	11	6	17	50	0	12.2	0.1	1	28.85	93.4	6.5313	62.4009
2025	11	6	18	0	0	12.2	0.1	1	28.01	91.6	6.5313	60.6675
2025	11	6	18	10	0	12.2	0.1	1	27.83	92.5	6.5313	60.2342
2025	11	6	18	20	0	12.2	0.1	1	28.33	92.6	6.5313	61.3175
2025	11	6	18	30	0	12.2	0.1	1	28.9	90.8	6.5313	62.6176
2025	11	6	18	40	0	12.2	0.1	1	28.96	93.8	6.5313	62.6176
2025	11	6	18	50	0	12.2	0.1	1	27.54	93.1	6.5313	59.5842
2025	11	6	19	0	0	12.2	0.1	1	28.23	92.6	6.5374	61.1604
2025	11	6	19	10	0	12.2	0.1	1	28.73	92.8	6.5374	62.2448
2025	11	6	19	20	0	12.2	0.1	1	27.61	95.2	6.5374	59.6423
2025	11	6	19	30	0	12	0.1	1	28.42	92.2	6.5374	61.5943
2025	11	6	19	40	0	12	0.1	1	27.85	93.5	6.5374	60.293
2025	11	6	19	50	0	12	0.1	1	28.82	92	6.5374	62.4619
2025	11	6	20	0	0	12	0.1	1	28.75	93.4	6.5374	62.245
2025	11	6	20	10	0	12	0.1	1	28.73	92.8	6.5374	62.2451
2025	11	6	20	20	0	12	0.1	1	28.05	93.3	6.5374	60.7269
2025	11	6	20	30	0	12	0.1	1	27.86	93.9	6.5374	60.2932
2025	11	6	20	40	0	12	0.1	1	28.36	93.8	6.5434	61.4373
2025	11	6	20	50	0	12	0.1	1	28.06	93.9	6.5495	60.8451
2025	11	6	21	0	0	12	0.1	1	28.68	94.4	6.5495	62.1489
2025	11	6	21	10	0	12	0.1	1	28.85	93.4	6.5556	62.6443
2025	11	6	21	20	0	12	0.1	1	27.91	91.4	6.5556	60.6867
2025	11	6	21	30	0	12	0.1	1	29.49	94.5	6.5556	63.9495
2025	11	6	21	40	0	12	0.1	1	28.42	95.2	6.5556	61.5568
2025	11	6	21	50	0	12	0.1	1	29.14	93.1	6.5556	63.297
2025	11	6	22	0	0	12	0.1	1	28.62	92.2	6.5556	62.2095
2025	11	6	22	10	0	12	0.1	1	28.13	92.6	6.5556	61.1219
2025	11	6	22	20	0	12	0.1	1	26.98	94.5	6.5556	58.5118
2025	11	6	22	30	0	12	0.1	1	28.68	94.4	6.5556	62.2096
2025	11	6	22	40	0	12	0.1	1	28.28	94.3	6.5556	61.3395
2025	11	6	22	50	0	12	0.1	1	28.43	92.4	6.5556	61.7746
2025	11	6	23	0	0	12	0.1	1	27.58	94.4	6.5556	59.817
2025	11	6	23	10	0	12	0.1	1	29.16	93.7	6.5556	63.2973
2025	11	6	23	20	0	12	0.1	1	28.84	93.2	6.5556	62.6448
2025	11	6	23	30	0	12	0.1	1	28.76	93.6	6.5556	62.4273
2025	11	6	23	40	0	12	0.1	1	27.48	94.4	6.5556	59.5996
2025	11	6	23	50	0	12	0.1	1	28.94	93.2	6.5556	62.8624

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	7	0	0	0	12	0.1	1	28.71	91.6	6.5556	62.4274
2025	11	7	0	10	0	12	0.1	1	27.85	93.5	6.5556	60.4698
2025	11	7	0	20	0	12	0.1	1	27.77	94.1	6.5556	60.2523
2025	11	7	0	30	0	12	0.1	1	29.2	94.7	6.5556	63.2976
2025	11	7	0	40	0	12	0.1	1	28.33	92.8	6.5556	61.5574
2025	11	7	0	50	0	12	0.1	1	27.94	93.1	6.5556	60.6874
2025	11	7	1	0	0	12	0.1	1	28.25	93.4	6.5556	61.34
2025	11	7	1	10	0	12	0.1	1	28.87	94	6.5556	62.6451
2025	11	7	1	20	0	12	0.1	1	27.13	92.7	6.5556	58.9474
2025	11	7	1	30	0	12	0.1	1	28.43	92.4	6.5556	61.7751
2025	11	7	1	40	0	12	0.1	1	28.31	91.8	6.5556	61.5576
2025	11	7	1	50	0	12	0.1	1	28.27	94.1	6.5556	61.3401
2025	11	7	2	0	0	12	0.1	1	29.15	93.3	6.5556	63.2978
2025	11	7	2	10	0	12	0.1	1	28.71	91.8	6.5556	62.4278
2025	11	7	2	20	0	11.8	0.1	1	28.15	93.5	6.5556	61.1227
2025	11	7	2	30	0	11.8	0.1	1	28.39	94.6	6.5556	61.5578
2025	11	7	2	40	0	11.8	0.1	1	28.58	94.2	6.5556	61.9928
2025	11	7	2	50	0	11.8	0.1	1	28.68	94.2	6.5556	62.2104
2025	11	7	3	0	0	11.8	0.1	1	27.53	92.7	6.5556	59.8177
2025	11	7	3	10	0	11.8	0.1	1	28.28	94.3	6.5556	61.3403
2025	11	7	3	20	0	11.8	0.1	1	29.37	93.9	6.5556	63.7331
2025	11	7	3	30	0	11.8	0.1	1	28.26	93.9	6.5556	61.3404
2025	11	7	3	40	0	11.8	0.1	1	28.25	93.2	6.5556	61.3404
2025	11	7	3	50	0	11.8	0.1	1	28.16	93.7	6.5556	61.1229
2025	11	7	4	0	0	11.8	0.1	1	27.91	91.8	6.5556	60.6879
2025	11	7	4	10	0	11.8	0.1	1	29.39	94.5	6.5556	63.7332
2025	11	7	4	20	0	11.8	0.1	1	28.35	95.9	6.5556	61.3405
2025	11	7	4	30	0	11.8	0.1	1	27.81	91.6	6.5556	60.4704
2025	11	7	4	40	0	11.8	0.1	1	27.81	95.2	6.5556	60.2529
2025	11	7	4	50	0	11.8	0.1	1	28.87	94	6.5556	62.6456
2025	11	7	5	0	0	11.8	0.1	1	28.55	93.4	6.5556	61.9931
2025	11	7	5	10	0	11.8	0.1	1	28.06	93.7	6.5556	60.9055
2025	11	7	5	20	0	11.8	0.1	1	28.64	93	6.5556	62.2106
2025	11	7	5	30	0	11.8	0.1	1	27.35	93.6	6.5556	59.3829
2025	11	7	5	40	0	11.8	0.1	1	28.58	94.4	6.5556	61.9931
2025	11	7	5	50	0	11.8	0.1	1	28.23	92.4	6.5556	61.3406
2025	11	7	6	0	0	11.8	0.1	1	30	94.6	6.5556	65.0385
2025	11	7	6	10	0	11.8	0.1	1	28.88	94.2	6.5556	62.6458
2025	11	7	6	20	0	11.8	0.1	1	27.94	95.8	6.5556	60.4706
2025	11	7	6	30	0	11.8	0.1	1	28.11	95.1	6.5556	60.9056
2025	11	7	6	40	0	11.8	0.1	1	29.24	93.1	6.5556	63.5159
2025	11	7	6	50	0	11.8	0.1	1	28.88	94.2	6.5556	62.6458
2025	11	7	7	0	0	11.8	0.1	1	28.47	94	6.5556	61.7758
2025	11	7	7	10	0	11.8	0.1	1	28.29	94.5	6.5556	61.3407
2025	11	7	7	20	0	11.8	0.1	1	29.33	92.5	6.5556	63.7335
2025	11	7	7	30	0	11.8	0.1	1	28.39	96.7	6.5556	61.3408
2025	11	7	7	40	0	11.8	0.1	1	28.23	92.8	6.5556	61.3408
2025	11	7	7	50	0	11.8	0.1	1	27.51	91.7	6.5556	59.8182

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	7	8	0	0	11.8	0.1	1	27.92	92.3	6.5556	60.6883
2025	11	7	8	10	0	11.8	0.1	1	27.61	95.2	6.5556	59.8182
2025	11	7	8	20	0	12.4	0.1	1	29.28	94.1	6.5556	63.5161
2025	11	7	8	30	0	12.8	0.1	1	29.35	93.3	6.5556	63.7336
2025	11	7	8	40	0	13	0.1	1	27.7	94.8	6.5556	60.0358
2025	11	7	8	50	0	13	0.1	1	28.88	96.4	6.5556	62.4285
2025	11	7	9	0	0	13	0.1	1	27.25	93.6	6.5556	59.1657
2025	11	7	9	10	0	13.2	0.1	1	28.29	94.5	6.5556	61.3409
2025	11	7	9	20	0	13.2	0.1	1	29.14	93	6.5556	63.2986
2025	11	7	9	30	0	13.2	0.1	1	27.25	93.4	6.5556	59.1657
2025	11	7	9	40	0	13.4	0.1	1	28.83	92.6	6.5556	62.646
2025	11	7	9	50	0	13.4	0.1	1	29.19	94.5	6.5556	63.2986
2025	11	7	10	0	0	13.4	0.1	1	28.45	93.2	6.5556	61.7759
2025	11	7	10	10	0	13.6	0.1	1	28.71	95	6.5556	62.2109
2025	11	7	10	20	0	13.8	0.1	1	28.34	93	6.5556	61.5583
2025	11	7	10	30	0	13.8	0.1	1	28.85	93.4	6.5556	62.6459
2025	11	7	10	40	0	13.6	0.1	1	29.5	94.7	6.5556	63.951
2025	11	7	10	50	0	13.6	0.1	1	28.88	94.2	6.5556	62.6458
2025	11	7	11	0	0	13.6	0.1	1	28.58	94.4	6.5556	61.9932
2025	11	7	11	10	0	13.6	0.1	1	27.81	95.2	6.5556	60.253
2025	11	7	11	20	0	14.2	0.1	1	27.66	93.7	6.5556	60.0355
2025	11	7	11	30	0	14.2	0.1	1	27.55	93.5	6.5556	59.8179
2025	11	7	11	40	0	14.2	0.1	1	28.57	94	6.5556	61.9931
2025	11	7	11	50	0	14.2	0.1	1	28.08	94.3	6.5556	60.9054
2025	11	7	12	0	0	14.2	0.1	1	27.73	92.7	6.5556	60.2528
2025	11	7	12	10	0	14.2	0.1	1	28.36	93.6	6.5617	61.6175
2025	11	7	12	20	0	14.2	0.1	1	29.09	94.5	6.5617	63.1416
2025	11	7	12	30	0	14	0.1	1	28.62	95.2	6.5617	62.0529
2025	11	7	12	40	0	14.2	0.1	1	27.76	93.7	6.5617	60.311
2025	11	7	12	50	0	14.2	0.1	1	27.46	93.8	6.5617	59.6578
2025	11	7	13	0	0	14.2	0.1	1	28.73	92.4	6.5617	62.4882
2025	11	7	13	10	0	14.2	0.1	1	28	94.9	6.5617	60.7463
2025	11	7	13	20	0	14	0.1	1	28.94	95.6	6.5617	62.7058
2025	11	7	13	30	0	14.2	0.1	1	28.48	96.5	6.5617	61.6171
2025	11	7	13	40	0	14.2	0.1	1	28.58	94.2	6.5617	62.0525
2025	11	7	13	50	0	14	0.1	1	28.4	94.8	6.5617	61.617
2025	11	7	14	0	0	14	0.1	1	28.09	94.7	6.5617	60.9638
2025	11	7	14	10	0	14	0.1	1	29.51	94.9	6.5617	64.0119
2025	11	7	14	20	0	13.8	0.1	1	28.62	95.2	6.5617	62.0523
2025	11	7	14	30	0	13.8	0.1	1	28.63	92.4	6.5617	62.27
2025	11	7	14	40	0	13.8	0.1	1	29.4	96.6	6.5617	63.5764
2025	11	7	14	50	0	13.8	0.1	1	28.47	94	6.5617	61.8345
2025	11	7	15	0	0	13.8	0.1	1	28.58	94.2	6.5617	62.0522
2025	11	7	15	10	0	13.6	0.1	1	27.98	94.3	6.5617	60.7458
2025	11	7	15	20	0	13.6	0.1	1	28.44	93	6.5617	61.8344
2025	11	7	15	30	0	13.4	0.1	1	28.02	92.2	6.5617	60.9635
2025	11	7	15	40	0	13.4	0.1	1	27.96	93.7	6.5617	60.7457
2025	11	7	15	50	0	13.4	0.1	1	27.47	94.2	6.5617	59.657

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	7	16	0	0	13.4	0.1	1	28.24	93	6.5617	61.3988
2025	11	7	16	10	0	13.4	0.1	1	28.17	94.1	6.5617	61.1811
2025	11	7	16	20	0	13.2	0.1	1	28.84	93.2	6.5617	62.7052
2025	11	7	16	30	0	13.2	0.1	1	28.13	92.6	6.5617	61.1811
2025	11	7	16	40	0	13.2	0.1	1	27.85	93.5	6.5617	60.5279
2025	11	7	16	50	0	13.2	0.1	1	28.03	92.9	6.5617	60.9633
2025	11	7	17	0	0	13.2	0.1	1	27.78	94.3	6.5617	60.3101
2025	11	7	17	10	0	11.8	0.1	1	28.49	94.6	6.5617	61.8342
2025	11	7	17	20	0	12.2	0.1	1	29.72	92.3	6.5678	64.7272
2025	11	7	17	30	0	12.2	0.1	1	27.65	93.5	6.5678	60.1505
2025	11	7	17	40	0	12.2	0.1	1	29.42	91.9	6.5678	64.0734
2025	11	7	17	50	0	12.2	0.1	1	27.38	94.4	6.5678	59.4967
2025	11	7	18	0	0	12.2	0.1	1	28.68	94.2	6.5678	62.3299
2025	11	7	18	10	0	12.2	0.1	1	29.38	94.1	6.5678	63.8555
2025	11	7	18	20	0	12.2	0.1	1	27.79	94.5	6.5678	60.3685
2025	11	7	18	30	0	12.2	0.1	1	28.36	93.8	6.5678	61.6761
2025	11	7	18	40	0	12.2	0.1	1	29.08	94.1	6.5678	63.2017
2025	11	7	18	50	0	12.2	0.1	1	29.36	93.7	6.5678	63.8555
2025	11	7	19	0	0	12.2	0.1	1	27.33	92.7	6.5678	59.4968
2025	11	7	19	10	0	12.2	0.1	1	28.81	91.8	6.5678	62.7659
2025	11	7	19	20	0	12	0.1	1	29.53	95.4	6.5678	64.0735
2025	11	7	19	30	0	12	0.1	1	28.54	93.2	6.5678	62.1121
2025	11	7	19	40	0	12	0.1	1	29.14	93.1	6.5678	63.4198
2025	11	7	19	50	0	12	0.1	1	29.01	91.2	6.5678	63.2019
2025	11	7	20	0	0	12	0.1	1	28.63	92.8	6.5678	62.3302
2025	11	7	20	10	0	12	0.1	1	30.04	92.9	6.5678	65.3813
2025	11	7	20	20	0	12	0.1	1	28.44	93	6.5739	61.9542
2025	11	7	20	30	0	12	0.1	1	28.13	92.9	6.5678	61.2406
2025	11	7	20	40	0	12	0.1	1	28.03	92.7	6.5739	61.0817
2025	11	7	20	50	0	12	0.1	1	28.64	93.2	6.5739	62.3906
2025	11	7	21	0	0	12	0.1	1	28.25	95.9	6.5678	61.2407
2025	11	7	21	10	0	12	0.1	1	28.41	91.8	6.5678	61.8945
2025	11	7	21	20	0	12	0.1	1	29.01	91.4	6.5678	63.2022
2025	11	7	21	30	0	12	0.1	1	28.42	95.2	6.5678	61.6766
2025	11	7	21	40	0	12	0.1	1	28.03	92.5	6.5678	61.0228
2025	11	7	21	50	0	12	0.1	1	28.28	94.3	6.5678	61.4587
2025	11	7	22	0	0	12	0.1	1	28.8	91	6.5678	62.7664
2025	11	7	22	10	0	12	0.1	1	28.08	94.3	6.5678	61.0229
2025	11	7	22	20	0	12	0.1	1	27.35	93.6	6.5678	59.4974
2025	11	7	22	30	0	12	0.1	1	28.75	93.4	6.5678	62.5486
2025	11	7	22	40	0	12	0.1	1	27.99	94.5	6.5678	60.8051
2025	11	7	22	50	0	12	0.1	1	28.26	93.7	6.5678	61.4589
2025	11	7	23	0	0	12	0.1	1	29.48	94.3	6.5678	64.0742
2025	11	7	23	10	0	12	0.1	1	28.32	95.3	6.5678	61.459
2025	11	7	23	20	0	12	0.1	1	29.19	94.5	6.5678	63.4205
2025	11	7	23	30	0	12	0.1	1	28.39	94.6	6.5678	61.677
2025	11	7	23	40	0	12	0.1	1	27.86	93.7	6.5678	60.5873
2025	11	7	23	50	0	12	0.1	1	27.15	93.6	6.5678	59.0618

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	8	0	0	0	12	0.1	1	28.66	93.6	6.5678	62.3309
2025	11	8	0	10	0	12	0.1	1	27.84	92.9	6.5678	60.5874
2025	11	8	0	20	0	12	0.1	1	27.75	93.5	6.5678	60.3695
2025	11	8	0	30	0	12	0.1	1	28.18	94.3	6.5678	61.2413
2025	11	8	0	40	0	12	0.1	1	27.75	93.3	6.5617	60.3112
2025	11	8	0	50	0	12	0.1	1	28.65	93.4	6.5678	62.3311
2025	11	8	1	0	0	12	0.1	1	27.65	93.3	6.5678	60.1517
2025	11	8	1	10	0	12	0.1	1	26.45	93.5	6.5678	57.5364
2025	11	8	1	20	0	12	0.1	1	27.73	92.7	6.5617	60.3113
2025	11	8	1	30	0	12	0.1	1	28.13	92.9	6.5678	61.2415
2025	11	8	1	40	0	12	0.1	1	28.37	94	6.5617	61.6177
2025	11	8	1	50	0	12	0.1	1	28.54	93	6.5617	62.0532
2025	11	8	2	0	0	12	0.1	1	28.46	93.8	6.5617	61.8355
2025	11	8	2	10	0	12	0.1	1	27.74	92.9	6.5617	60.3114
2025	11	8	2	20	0	12	0.1	1	28.11	95.1	6.5617	60.9646
2025	11	8	2	30	0	11.8	0.1	1	29.06	93.7	6.5617	63.1419
2025	11	8	2	40	0	11.8	0.1	1	28.15	93.5	6.5617	61.1824
2025	11	8	2	50	0	11.8	0.1	1	28.03	92.7	6.5617	60.9647
2025	11	8	3	0	0	11.8	0.1	1	29.07	93.9	6.5617	63.142
2025	11	8	3	10	0	11.8	0.1	1	28.63	92.6	6.5617	62.2711
2025	11	8	3	20	0	11.8	0.1	1	28.65	93.4	6.5617	62.2711
2025	11	8	3	30	0	11.8	0.1	1	29.5	94.7	6.5617	64.013
2025	11	8	3	40	0	11.8	0.1	1	28.1	94.9	6.5617	60.9648
2025	11	8	3	50	0	11.8	0.1	1	28.95	93.4	6.5617	62.9243
2025	11	8	4	0	0	11.8	0.1	1	28.4	94.8	6.5617	61.618
2025	11	8	4	10	0	11.8	0.1	1	28.85	93.4	6.5617	62.7066
2025	11	8	4	20	0	11.8	0.1	1	28.52	95.2	6.5617	61.8357
2025	11	8	4	30	0	11.8	0.1	1	28.48	94.2	6.5617	61.8357
2025	11	8	4	40	0	11.8	0.1	1	29.03	92.8	6.5617	63.1421
2025	11	8	4	50	0	11.8	0.1	1	28.11	95.1	6.5617	60.9648
2025	11	8	5	0	0	11.8	0.1	1	29.36	93.7	6.5617	63.7954
2025	11	8	5	10	0	11.8	0.1	1	28.01	95.1	6.5617	60.7471
2025	11	8	5	20	0	11.8	0.1	1	28.87	94	6.5617	62.7067
2025	11	8	5	30	0	11.8	0.1	1	27.49	94.6	6.5617	59.6585
2025	11	8	5	40	0	11.8	0.1	1	28.46	93.6	6.5617	61.8358
2025	11	8	5	50	0	11.8	0.1	1	29.41	91.6	6.5617	64.0131
2025	11	8	6	0	0	11.8	0.1	1	28.58	94.4	6.5617	62.0536
2025	11	8	6	10	0	11.8	0.1	1	27.53	92.5	6.5617	59.8762
2025	11	8	6	20	0	11.8	0.1	1	28.46	96.1	6.5617	61.6181
2025	11	8	6	30	0	11.8	0.1	1	28.79	94.6	6.5617	62.489
2025	11	8	6	40	0	11.8	0.1	1	28.3	94.9	6.5617	61.4004
2025	11	8	6	50	0	11.8	0.1	1	29.5	94.7	6.5617	64.0132
2025	11	8	7	0	0	11.8	0.1	1	28.41	95	6.5617	61.6181
2025	11	8	7	10	0	11.8	0.1	1	28.98	94.2	6.5617	62.9245
2025	11	8	7	20	0	11.8	0.1	1	28.73	92.8	6.5617	62.4891
2025	11	8	7	30	0	11.6	0.1	1	27.53	92.7	6.5617	59.8763
2025	11	8	7	40	0	11.6	0.1	1	28.33	92.4	6.5617	61.6182
2025	11	8	7	50	0	11.6	0.1	1	27.95	93.3	6.5617	60.7473

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	8	8	0	0	11.6	0.1	1	29.23	95.5	6.5617	63.3601
2025	11	8	8	10	0	11.6	0.1	1	28.51	95	6.5617	61.8359
2025	11	8	8	20	0	12.2	0.1	1	27.89	94.7	6.5617	60.5296
2025	11	8	8	30	0	12.6	0.1	1	28.98	94.2	6.5617	62.9246
2025	11	8	8	40	0	13	0.1	1	28.88	94.4	6.5617	62.7069
2025	11	8	8	50	0	13	0.1	1	28.37	94	6.5617	61.6182
2025	11	8	9	0	0	13	0.1	1	28.14	93.1	6.5617	61.1827
2025	11	8	9	10	0	13	0.1	1	28.6	94.8	6.5617	62.0537
2025	11	8	9	20	0	13.2	0.1	1	28.09	94.5	6.5617	60.965
2025	11	8	9	30	0	13.4	0.1	1	26.87	94.3	6.5617	58.3522
2025	11	8	9	40	0	13.4	0.1	1	27.93	92.7	6.5617	60.7472
2025	11	8	9	50	0	14.2	0.1	1	28.68	94.2	6.5617	62.2713
2025	11	8	10	0	0	14.2	0.1	1	28.01	95.1	6.5617	60.7472
2025	11	8	10	10	0	14.2	0.1	1	27.6	96.9	6.5617	59.6585
2025	11	8	10	20	0	14.2	0.1	1	27.98	94.3	6.5617	60.7471
2025	11	8	10	30	0	14.2	0.1	1	29.58	94.3	6.5617	64.2308
2025	11	8	10	40	0	14.2	0.1	1	28.21	95.1	6.5617	61.1825
2025	11	8	10	50	0	14.2	0.1	1	29.23	92.7	6.5617	63.5775
2025	11	8	11	0	0	14.2	0.1	1	28.16	93.7	6.5617	61.1824
2025	11	8	11	10	0	14.2	0.1	1	27.98	94.3	6.5617	60.7469
2025	11	8	11	20	0	14.2	0.1	1	27.81	95.2	6.5617	60.3114
2025	11	8	11	30	0	14.2	0.1	1	26.94	93	6.5617	58.5695
2025	11	8	11	40	0	14.2	0.1	1	27.87	94.1	6.5617	60.529
2025	11	8	11	50	0	14.2	0.1	1	27.21	91.7	6.5617	59.2226
2025	11	8	12	0	0	14.2	0.1	1	29	94.7	6.5617	62.9239
2025	11	8	12	10	0	14.2	0.1	1	28.06	93.7	6.5617	60.9643
2025	11	8	12	20	0	14.2	0.1	1	29.87	94	6.5617	64.8834
2025	11	8	12	30	0	14.2	0.1	1	27.17	94	6.5617	59.0046
2025	11	8	12	40	0	14.2	0.1	1	28.31	95.1	6.5617	61.3996
2025	11	8	12	50	0	14.2	0.1	1	28.36	93.8	6.5678	61.6769
2025	11	8	13	0	0	14.2	0.1	1	28.13	92.9	6.5678	61.241
2025	11	8	13	10	0	14.2	0.1	1	27.45	96.1	6.5678	59.4974
2025	11	8	13	20	0	14.2	0.1	1	27.37	94	6.5678	59.4974
2025	11	8	13	30	0	14.2	0.1	1	28.88	94.2	6.5678	62.7664
2025	11	8	13	40	0	14.2	0.1	1	27.63	95.6	6.5678	59.9331
2025	11	8	13	50	0	14.2	0.1	1	27.12	95.3	6.5678	58.8434
2025	11	8	14	0	0	14.2	0.1	1	27.69	94.6	6.5678	60.151
2025	11	8	14	10	0	14.2	0.1	1	28.05	95.9	6.5678	60.8047
2025	11	8	14	20	0	13.4	0.1	1	28.12	95.3	6.5678	61.0226
2025	11	8	14	30	0	14	0.1	1	26.87	94.3	6.5678	58.4073
2025	11	8	14	40	0	14	0.1	1	27.41	95	6.5678	59.497
2025	11	8	14	50	0	14	0.1	1	26.75	93.6	6.5678	58.1893
2025	11	8	15	0	0	13.8	0.1	1	27.31	91.7	6.5678	59.4969
2025	11	8	15	10	0	13.8	0.1	1	28.06	93.9	6.5678	61.0224
2025	11	8	15	20	0	13.2	0.1	1	28.15	93.5	6.5678	61.2403
2025	11	8	15	30	0	13.2	0.1	1	28.49	94.6	6.5678	61.8941
2025	11	8	15	40	0	13.6	0.1	1	28.05	93.3	6.5678	61.0223
2025	11	8	15	50	0	13.4	0.1	1	28.73	95.4	6.5678	62.3299

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	8	16	0	0	13.4	0.1	1	28.62	95.2	6.5678	62.1119
2025	11	8	16	10	0	13.4	0.1	1	29.07	96.1	6.5678	62.9837
2025	11	8	16	20	0	13.2	0.1	1	27.8	96.8	6.5678	60.1505
2025	11	8	16	30	0	13.2	0.1	1	27.53	92.7	6.5678	59.9325
2025	11	8	16	40	0	13.2	0.1	1	28.7	94.8	6.5678	62.3298
2025	11	8	16	50	0	13.2	0.1	1	29.12	95.1	6.5678	63.2015
2025	11	8	17	0	0	13	0.1	1	28.95	95.7	6.5678	62.7656
2025	11	8	17	10	0	11.8	0.1	1	27.54	95.8	6.5678	59.7145
2025	11	8	17	20	0	12.2	0.1	1	28.03	92.9	6.5678	61.0221
2025	11	8	17	30	0	12.2	0.1	1	29.19	94.5	6.5678	63.4194
2025	11	8	17	40	0	12.2	0.1	1	28.36	93.6	6.5678	61.6759
2025	11	8	17	50	0	12.2	0.1	1	28.01	95.1	6.5678	60.8042
2025	11	8	18	0	0	12.2	0.1	1	28.18	94.3	6.5678	61.24
2025	11	8	18	10	0	12.2	0.1	1	28.86	93.8	6.5678	62.7656
2025	11	8	18	20	0	12.2	0.1	1	28.84	93.2	6.5678	62.7656
2025	11	8	18	30	0	12.2	0.1	1	28.6	96.8	6.5678	61.8939
2025	11	8	18	40	0	12.2	0.1	1	26.9	94.9	6.5678	58.4069
2025	11	8	18	50	0	12	0.1	1	28.05	93.5	6.5678	61.0221
2025	11	8	19	0	0	12	0.1	1	28.18	94.3	6.5678	61.2401
2025	11	8	19	10	0	12	0.1	1	29.11	91.8	6.5678	63.4195
2025	11	8	19	20	0	12	0.1	1	28.03	92.7	6.5678	61.0222
2025	11	8	19	30	0	12	0.1	1	27.82	92.1	6.5678	60.5863
2025	11	8	19	40	0	12	0.1	1	27.62	95.4	6.5678	59.9326
2025	11	8	19	50	0	12	0.1	1	27.83	92.7	6.5678	60.5864
2025	11	8	20	0	0	12	0.1	1	28.78	94.2	6.5678	62.5478
2025	11	8	20	10	0	12	0.1	1	28.26	93.9	6.5678	61.4582
2025	11	8	20	20	0	12	0.1	1	28.15	93.5	6.5678	61.2403
2025	11	8	20	30	0	12	0.1	1	29.16	93.7	6.5678	63.4197
2025	11	8	20	40	0	12	0.1	1	29.08	94.1	6.5678	63.2018
2025	11	8	20	50	0	12	0.1	1	28.18	94.3	6.5678	61.2404
2025	11	8	21	0	0	12	0.1	1	28.38	94.2	6.5678	61.6763
2025	11	8	21	10	0	12	0.1	1	28.79	94.6	6.5678	62.548
2025	11	8	21	20	0	12	0.1	1	27.8	95	6.5678	60.3687
2025	11	8	21	30	0	12	0.1	1	28.57	94	6.5678	62.1122
2025	11	8	21	40	0	12	0.1	1	29.87	93.8	6.5678	64.9454
2025	11	8	21	50	0	12	0.1	1	28.01	91.8	6.5678	61.0226
2025	11	8	22	0	0	12	0.1	1	28.51	95	6.5678	61.8944
2025	11	8	22	10	0	12	0.1	1	28.63	92.8	6.5678	62.3303
2025	11	8	22	20	0	12	0.1	1	28.1	90.8	6.5617	61.1814
2025	11	8	22	30	0	12	0.1	1	28.15	93.5	6.5617	61.1814
2025	11	8	22	40	0	12	0.1	1	28.02	92	6.5617	60.9637
2025	11	8	22	50	0	12	0.1	1	28.35	93.4	6.5617	61.6169
2025	11	8	23	0	0	12	0.1	1	28.48	94.2	6.5617	61.8347
2025	11	8	23	10	0	12	0.1	1	27.78	94.3	6.5617	60.3106
2025	11	8	23	20	0	12	0.1	1	28.23	95.5	6.5617	61.1815
2025	11	8	23	30	0	12	0.1	1	28.79	94.6	6.5617	62.4879
2025	11	8	23	40	0	12	0.1	1	27.95	93.5	6.5617	60.7461
2025	11	8	23	50	0	12	0.1	1	28.45	93.2	6.5617	61.8348

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	9	0	0	0	12	0.1	1	27.65	93.3	6.5617	60.093
2025	11	9	0	10	0	12	0.1	1	27.54	92.9	6.5556	59.8173
2025	11	9	0	20	0	12	0.1	1	29.37	93.9	6.5556	63.7327
2025	11	9	0	30	0	12	0.1	1	27.64	92.9	6.5556	60.0349
2025	11	9	0	40	0	12	0.1	1	28.56	93.6	6.5556	61.9926
2025	11	9	0	50	0	12	0.1	1	28.64	95.6	6.5556	61.9926
2025	11	9	1	0	0	12	0.1	1	28.63	92.4	6.5556	62.2102
2025	11	9	1	10	0	12	0.1	1	27.34	92.9	6.5556	59.3825
2025	11	9	1	20	0	12	0.1	1	29.05	95.7	6.5556	62.8628
2025	11	9	1	30	0	12	0.1	1	28.21	95.1	6.5556	61.1227
2025	11	9	1	40	0	12	0.1	1	28.34	95.7	6.5556	61.3402
2025	11	9	1	50	0	12	0.1	1	28.25	93.4	6.5495	61.2808
2025	11	9	2	0	0	12	0.1	1	27.86	96.2	6.5495	60.1943
2025	11	9	2	10	0	11.8	0.1	1	27.35	93.6	6.5495	59.3251
2025	11	9	2	20	0	11.8	0.1	1	28.31	95.1	6.5495	61.2808
2025	11	9	2	30	0	11.8	0.1	1	28.46	93.8	6.5495	61.7155
2025	11	9	2	40	0	11.8	0.1	1	29.46	93.7	6.5495	63.8886
2025	11	9	2	50	0	11.8	0.1	1	28.92	95.2	6.5495	62.5848
2025	11	9	3	0	0	11.8	0.1	1	27.77	93.9	6.5495	60.1944
2025	11	9	3	10	0	11.8	0.1	1	27.31	95.3	6.5495	59.1079
2025	11	9	3	20	0	11.8	0.1	1	27.39	94.6	6.5495	59.3252
2025	11	9	3	30	0	11.8	0.1	1	27.85	96	6.5434	60.1361
2025	11	9	3	40	0	11.8	0.1	1	27.41	95	6.5495	59.3252
2025	11	9	3	50	0	11.8	0.1	1	28.77	94	6.5434	62.3071
2025	11	9	4	0	0	11.8	0.1	1	27.71	97	6.5434	59.7019
2025	11	9	4	10	0	11.8	0.1	1	28.42	95.2	6.5434	61.4387
2025	11	9	4	20	0	11.8	0.1	1	29.64	95.6	6.5434	64.0439
2025	11	9	4	30	0	11.8	0.1	1	27.35	96.1	6.5434	59.0507
2025	11	9	4	40	0	11.8	0.1	1	26.98	94.5	6.5434	58.3994
2025	11	9	4	50	0	11.8	0.1	1	27.89	94.7	6.5434	60.3533
2025	11	9	5	0	0	11.8	0.1	1	28.47	96.3	6.5374	61.3791
2025	11	9	5	10	0	11.8	0.1	1	28.42	95.2	6.5374	61.3791
2025	11	9	5	20	0	11.8	0.1	1	27.98	94.3	6.5374	60.5116
2025	11	9	5	30	0	11.8	0.1	1	27.45	93.6	6.5374	59.4272
2025	11	9	5	40	0	11.8	0.1	1	28.51	95	6.5374	61.5961
2025	11	9	5	50	0	11.8	0.1	1	27.23	95.7	6.5374	58.7765
2025	11	9	6	0	0	11.8	0.1	1	27.3	94.8	6.5374	58.9934
2025	11	9	6	10	0	11.8	0.1	1	28.21	95.1	6.5374	60.9454
2025	11	9	6	20	0	11.8	0.1	1	27.72	95.4	6.5374	59.861
2025	11	9	6	30	0	11.8	0.1	1	28.58	94.4	6.5374	61.813
2025	11	9	6	40	0	11.8	0.1	1	28.18	94.3	6.5374	60.9455
2025	11	9	6	50	0	11.8	0.1	1	27.7	94.8	6.5313	59.8028
2025	11	9	7	0	0	11.8	0.1	1	27.98	94.3	6.5313	60.4529
2025	11	9	7	10	0	11.8	0.1	1	28.09	94.5	6.5313	60.6696
2025	11	9	7	20	0	11.6	0.1	1	28.31	95.1	6.5313	61.103
2025	11	9	7	30	0	11.6	0.1	1	28.17	96.3	6.5313	60.6696
2025	11	9	7	40	0	11.6	0.1	1	28.77	96.2	6.5313	61.9697
2025	11	9	7	50	0	11.6	0.1	1	27.65	93.5	6.5313	59.8029

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	9	8	0	0	11.6	0.1	1	27.77	96.4	6.5313	59.8029
2025	11	9	8	10	0	11.6	0.1	1	27.94	92.9	6.5252	60.3942
2025	11	9	8	20	0	12.2	0.1	1	27.52	92.3	6.5191	59.4703
2025	11	9	8	30	0	12.6	0.1	1	27.83	95.6	6.5191	59.9029
2025	11	9	8	40	0	13	0.1	1	27.15	93.4	6.513	58.5482
2025	11	9	8	50	0	13	0.1	1	27.24	95.9	6.513	58.5482
2025	11	9	9	0	0	13.2	0.1	1	28.11	95.1	6.513	60.4926
2025	11	9	9	10	0	13.2	0.1	1	28.06	93.7	6.5069	60.4336
2025	11	9	9	20	0	13.2	0.1	1	27.67	94.1	6.5069	59.5702
2025	11	9	9	30	0	13.4	0.1	1	26.78	94.5	6.5069	57.6277
2025	11	9	9	40	0	13.8	0.1	1	27.45	93.6	6.5069	59.1385
2025	11	9	9	50	0	13.8	0.1	1	27.55	93.5	6.5008	59.2964
2025	11	9	10	0	0	13.8	0.1	1	27.65	93.3	6.5008	59.512
2025	11	9	10	10	0	13.8	0.1	1	28.49	94.6	6.5008	61.2369
2025	11	9	10	20	0	14.2	0.1	1	27.32	95.5	6.5008	58.6494
2025	11	9	10	30	0	14.2	0.1	1	26.88	94.5	6.5008	57.7869
2025	11	9	10	40	0	14.2	0.1	1	28.09	94.7	6.5008	60.3743
2025	11	9	10	50	0	14.2	0.1	1	26.77	98.2	6.5008	57.14
2025	11	9	11	0	0	14.2	0.1	1	26.87	98.1	6.5008	57.3556
2025	11	9	11	10	0	14.2	0.1	1	27.4	94.8	6.5008	58.8649
2025	11	9	11	20	0	14.2	0.1	1	25.82	97.6	6.5008	55.1992
2025	11	9	11	30	0	14.2	0.1	1	26.65	96	6.5008	57.1398
2025	11	9	11	40	0	14.2	0.1	1	27.14	95.9	6.5008	58.2179
2025	11	9	11	50	0	14.2	0.1	1	27.79	94.5	6.5008	59.7272
2025	11	9	12	0	0	14.2	0.1	1	27.95	96	6.5008	59.9427
2025	11	9	12	10	0	14.2	0.1	1	27.97	96.4	6.5008	59.9427
2025	11	9	12	20	0	14.2	0.1	1	26.87	94.1	6.5008	57.7864
2025	11	9	12	30	0	14.2	0.1	1	27.59	96.7	6.5008	59.0801
2025	11	9	12	40	0	14.2	0.1	1	28.06	96.1	6.5008	60.1581
2025	11	9	12	50	0	14.2	0.1	1	27.86	93.9	6.5008	59.9425
2025	11	9	13	0	0	14.2	0.1	1	27.74	93.1	6.5008	59.7268
2025	11	9	13	10	0	14.2	0.1	1	28.09	94.7	6.5008	60.3736
2025	11	9	13	20	0	14.2	0.1	1	28.39	94.4	6.5008	61.0204
2025	11	9	13	30	0	14.2	0.1	1	27.39	94.6	6.5008	58.8642
2025	11	9	13	40	0	14	0.1	1	28.31	95.1	6.5008	60.8047
2025	11	9	13	50	0	14	0.1	1	26.57	96.5	6.5008	56.9235
2025	11	9	14	0	0	14	0.1	1	27	94.9	6.5008	58.0016
2025	11	9	14	10	0	14	0.1	1	27.77	96.4	6.5008	59.5108
2025	11	9	14	20	0	14	0.1	1	27.68	94.4	6.5008	59.5108
2025	11	9	14	30	0	14	0.1	1	27.59	94.6	6.5008	59.2952
2025	11	9	14	40	0	13.8	0.1	1	27.36	93.8	6.5008	58.8639
2025	11	9	14	50	0	13.8	0.1	1	28.92	92.4	6.5008	62.3137
2025	11	9	15	0	0	13.8	0.1	1	28.36	93.8	6.5008	61.02
2025	11	9	15	10	0	13.8	0.1	1	27.85	93.5	6.5008	59.9419
2025	11	9	15	20	0	13.6	0.1	1	28.43	95.4	6.5008	61.0199
2025	11	9	15	30	0	13.6	0.1	1	27.78	94.3	6.5008	59.7262
2025	11	9	15	40	0	13.4	0.1	1	28.88	94.4	6.5008	62.098
2025	11	9	15	50	0	13.4	0.1	1	27.45	93.6	6.5008	59.0793

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	9	16	0	0	13.4	0.1	1	28.45	93.4	6.5008	61.2354
2025	11	9	16	10	0	13.4	0.1	1	28.08	94.3	6.5008	60.3729
2025	11	9	16	20	0	13.2	0.1	1	28.31	95.1	6.5008	60.8042
2025	11	9	16	30	0	13.2	0.1	1	28.77	94	6.5008	61.8822
2025	11	9	16	40	0	13.2	0.1	1	27.28	94.4	6.5008	58.648
2025	11	9	16	50	0	13.2	0.1	1	28.32	92	6.5008	61.0197
2025	11	9	17	0	0	12.2	0.1	1	28.39	94.4	6.5008	61.0197
2025	11	9	17	10	0	11.8	0.1	1	28.32	92	6.5008	61.0197
2025	11	9	17	20	0	12.2	0.1	1	27.67	94.1	6.5008	59.5104
2025	11	9	17	30	0	12.2	0.1	1	27.93	92.7	6.5008	60.1573
2025	11	9	17	40	0	12.2	0.1	1	28.29	94.7	6.5008	60.8041
2025	11	9	17	50	0	12.2	0.1	1	28.33	95.5	6.5008	60.8041
2025	11	9	18	0	0	12.2	0.1	1	28.35	93.4	6.5008	61.0197
2025	11	9	18	10	0	12.2	0.1	1	27.88	94.3	6.5008	59.9417
2025	11	9	18	20	0	12.2	0.1	1	27.7	94.8	6.5008	59.5104
2025	11	9	18	30	0	12.2	0.1	1	27.91	91.8	6.5008	60.1573
2025	11	9	18	40	0	12.2	0.1	1	28.28	94.3	6.5008	60.8042
2025	11	9	18	50	0	12	0.1	1	28.29	94.5	6.5008	60.8042
2025	11	9	19	0	0	12	0.1	1	27.91	95.1	6.5008	59.9417
2025	11	9	19	10	0	12	0.1	1	28.32	92.2	6.5008	61.0198
2025	11	9	19	20	0	12	0.1	1	28.62	95.2	6.5008	61.4511
2025	11	9	19	30	0	12	0.1	1	28.56	93.8	6.5008	61.4511
2025	11	9	19	40	0	12	0.1	1	28.46	93.6	6.5008	61.2356
2025	11	9	19	50	0	12	0.1	1	28.18	94.3	6.5008	60.5887
2025	11	9	20	0	0	12	0.1	1	27.37	94.2	6.5008	58.8638
2025	11	9	20	10	0	12	0.1	1	27.51	91.2	6.5008	59.2951
2025	11	9	20	20	0	12	0.1	1	27	94.9	6.5008	58.0014
2025	11	9	20	30	0	12	0.1	1	26.69	96.9	6.5008	57.139
2025	11	9	20	40	0	12	0.1	1	26.64	95.8	6.5008	57.139
2025	11	9	20	50	0	12	0.1	1	27.09	94.7	6.5008	58.2171
2025	11	9	21	0	0	12	0.1	1	27.48	94.4	6.5008	59.0796
2025	11	9	21	10	0	12	0.1	1	26.37	96.5	6.5008	56.4922
2025	11	9	21	20	0	12	0.1	1	27.94	93.1	6.5008	60.1578
2025	11	9	21	30	0	12	0.1	1	27.12	95.3	6.5008	58.2173
2025	11	9	21	40	0	12	0.1	1	27.68	98.1	6.5008	59.0798
2025	11	9	21	50	0	12	0.1	1	25.3	100.2	6.5008	53.6893
2025	11	9	22	0	0	12	0.1	1	26.35	97.9	6.5008	56.2768
2025	11	9	22	10	0	12	0.1	1	26.15	97.9	6.5008	55.8456
2025	11	9	22	20	0	12	0.1	1	25.24	98	6.5008	53.905
2025	11	9	22	30	0	12	0.1	1	26.8	97.1	6.5008	57.355
2025	11	9	22	40	0	12	0.1	1	25.23	97.7	6.5008	53.9051
2025	11	9	22	50	0	12	0.1	1	26.59	98.4	6.5008	56.7082
2025	11	9	23	0	0	12	0.1	1	25.63	97.6	6.5008	54.7676
2025	11	9	23	10	0	12	0.1	1	26.76	97.9	6.4947	57.0836
2025	11	9	23	20	0	12	0.1	1	26.56	98	6.5008	56.7082
2025	11	9	23	30	0	12	0.1	1	25.65	98.1	6.4947	54.7141
2025	11	9	23	40	0	12	0.1	1	26.49	99.8	6.5008	56.2771
2025	11	9	23	50	0	12	0.1	1	26.86	97.9	6.4947	57.2991

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	10	0	0	0	12	0.1	1	26.55	96.1	6.4947	56.8683
2025	11	10	0	10	0	12	0.1	1	27.14	95.9	6.4947	58.1608
2025	11	10	0	20	0	12	0.1	1	26.64	95.8	6.4947	57.0838
2025	11	10	0	30	0	12	0.1	1	26.94	95.8	6.4947	57.7301
2025	11	10	0	40	0	12	0.1	1	28.28	99.4	6.4947	60.0996
2025	11	10	0	50	0	12	0.1	1	28.21	96.9	6.4947	60.315
2025	11	10	1	0	0	12	0.1	1	27.03	98.9	6.4947	57.5147
2025	11	10	1	10	0	12	0.1	1	27.78	94.3	6.4947	59.6689
2025	11	10	1	20	0	12	0.1	1	26.63	95.6	6.4947	57.084
2025	11	10	1	30	0	12	0.1	1	27.39	94.6	6.4947	58.8073
2025	11	10	1	40	0	12	0.1	1	27.3	94.8	6.4947	58.5919
2025	11	10	1	50	0	11.8	0.1	1	27.49	94.6	6.4947	59.0227
2025	11	10	2	0	0	11.8	0.1	1	28.67	94	6.4947	61.6077
2025	11	10	2	10	0	11.8	0.1	1	27.01	95.1	6.4947	57.9457
2025	11	10	2	20	0	11.8	0.1	1	27.35	96.1	6.4947	58.592
2025	11	10	2	30	0	11.8	0.1	1	28.29	96.7	6.4947	60.5307
2025	11	10	2	40	0	11.8	0.1	1	27.09	96.8	6.4947	57.9458
2025	11	10	2	50	0	11.8	0.1	1	28.09	94.7	6.4947	60.3154
2025	11	10	3	0	0	11.8	0.1	1	27.18	94.4	6.4947	58.3767
2025	11	10	3	10	0	11.8	0.1	1	27.34	95.9	6.4947	58.5921
2025	11	10	3	20	0	11.8	0.1	1	27.04	97.7	6.4947	57.7305
2025	11	10	3	30	0	11.8	0.1	1	26.85	96	6.4947	57.5151
2025	11	10	3	40	0	11.8	0.1	1	27.06	96.2	6.4947	57.9459
2025	11	10	3	50	0	11.8	0.1	1	27.14	95.9	6.4947	58.1614
2025	11	10	4	0	0	11.8	0.1	1	27.38	96.5	6.4947	58.5922
2025	11	10	4	10	0	11.8	0.1	1	28.26	93.9	6.4947	60.7464
2025	11	10	4	20	0	11.8	0.1	1	27.61	95.2	6.4886	59.1805
2025	11	10	4	30	0	11.8	0.1	1	27.36	96.3	6.4886	58.5349
2025	11	10	4	40	0	11.8	0.1	1	26.97	94	6.4886	57.8893
2025	11	10	4	50	0	11.8	0.1	1	27.6	96.9	6.4947	59.0231
2025	11	10	5	0	0	11.8	0.1	1	27.74	95.8	6.4947	59.454
2025	11	10	5	10	0	11.8	0.1	1	27.18	94.4	6.4947	58.3769
2025	11	10	5	20	0	11.8	0.1	1	27.04	93.2	6.4947	58.1615
2025	11	10	5	30	0	11.8	0.1	1	26.86	93.8	6.4947	57.7307
2025	11	10	5	40	0	11.8	0.1	1	26.9	94.9	6.4947	57.7307
2025	11	10	5	50	0	11.8	0.1	1	29.56	93.7	6.4947	63.5469
2025	11	10	6	0	0	11.8	0.1	1	27.64	93.1	6.4947	59.454
2025	11	10	6	10	0	11.8	0.1	1	27.87	94.1	6.4947	59.8849
2025	11	10	6	20	0	11.8	0.1	1	28.46	93.6	6.4947	61.1774
2025	11	10	6	30	0	11.8	0.1	1	27.59	94.6	6.4947	59.2387
2025	11	10	6	40	0	11.8	0.1	1	27.68	94.4	6.4947	59.4541
2025	11	10	6	50	0	11.8	0.1	1	27.25	93.4	6.4947	58.5925
2025	11	10	7	0	0	11.8	0.1	1	27.8	96.8	6.4947	59.4541
2025	11	10	7	10	0	11.6	0.1	1	27.54	92.9	6.4947	59.2388
2025	11	10	7	20	0	11.6	0.1	1	27.4	94.8	6.4947	58.8079
2025	11	10	7	30	0	11.6	0.1	1	27.91	95.1	6.4947	59.885
2025	11	10	7	40	0	11.6	0.1	1	27.25	93.4	6.4947	58.5926
2025	11	10	7	50	0	11.6	0.1	1	27.81	95.2	6.4947	59.6696

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	10	8	0	0	11.6	0.1	1	28.11	95.1	6.4947	60.3159
2025	11	10	8	10	0	11.6	0.1	1	28.25	93.4	6.4886	60.6873
2025	11	10	8	20	0	12.2	0.1	1	28.21	95.1	6.4886	60.4721
2025	11	10	8	30	0	12.6	0.1	1	28.31	95.1	6.4886	60.6873
2025	11	10	8	40	0	13	0.1	1	28.01	95.1	6.4886	60.0417
2025	11	10	8	50	0	13	0.1	1	27.98	94.3	6.4886	60.0417
2025	11	10	9	0	0	13.2	0.1	1	28.76	96	6.4886	61.5481
2025	11	10	9	10	0	13	0.1	1	28.39	96.7	6.4886	60.6873
2025	11	10	9	20	0	13	0.1	1	26.69	94.7	6.4886	57.2441
2025	11	10	9	30	0	13.4	0.1	1	27.51	95.2	6.4886	58.9657
2025	11	10	9	40	0	13.4	0.1	1	28.42	97.1	6.4886	60.6873
2025	11	10	9	50	0	13.6	0.1	1	27.07	94.2	6.4886	58.1048
2025	11	10	10	0	0	14	0.1	1	27.88	94.3	6.4947	59.885
2025	11	10	10	10	0	14.2	0.1	1	27.29	94.6	6.4947	58.5925
2025	11	10	10	20	0	14.2	0.1	1	28.31	95.1	6.4947	60.7466
2025	11	10	10	30	0	14.2	0.1	1	27.7	94.8	6.4947	59.4541
2025	11	10	10	40	0	14.2	0.1	1	26.78	96.6	6.4947	57.3
2025	11	10	10	50	0	14.2	0.1	1	28.07	96.3	6.4947	60.1003
2025	11	10	11	0	0	14.2	0.1	1	26.95	96	6.4947	57.7307
2025	11	10	11	10	0	14.2	0.1	1	26.77	96.4	6.4947	57.2998
2025	11	10	11	20	0	14.2	0.1	1	28.3	94.9	6.4947	60.7464
2025	11	10	11	30	0	14.2	0.1	1	26.55	93.7	6.4947	57.0843
2025	11	10	11	40	0	14.2	0.1	1	27.62	95.4	6.4947	59.2384
2025	11	10	11	50	0	14.2	0.1	1	26.93	95.5	6.4947	57.7305
2025	11	10	12	0	0	14.2	0.1	1	27.64	95.8	6.4947	59.2383
2025	11	10	12	10	0	14.2	0.1	1	27.71	95.2	6.4947	59.4537
2025	11	10	12	20	0	14.2	0.1	1	27.69	94.6	6.4947	59.4536
2025	11	10	12	30	0	14.2	0.1	1	27.27	94.2	6.4947	58.5919
2025	11	10	12	40	0	14.2	0.1	1	28.09	94.7	6.4947	60.3152
2025	11	10	12	50	0	14.2	0.1	1	26.66	96.2	6.4947	57.0839
2025	11	10	13	0	0	14.2	0.1	1	27.27	94.2	6.4947	58.5918
2025	11	10	13	10	0	14.2	0.1	1	27.73	95.6	6.4947	59.4534
2025	11	10	13	20	0	14.2	0.1	1	28.18	94.3	6.5008	60.5896
2025	11	10	13	30	0	14.2	0.1	1	26.33	95.7	6.5008	56.4927
2025	11	10	13	40	0	14.2	0.1	1	27.77	94.1	6.5008	59.727
2025	11	10	13	50	0	14.2	0.1	1	27.28	94.4	6.5008	58.6489
2025	11	10	14	0	0	14.2	0.1	1	27.03	95.5	6.5008	58.0019
2025	11	10	14	10	0	14	0.1	1	27.87	96.4	6.5008	59.7269
2025	11	10	14	20	0	14.2	0.1	1	26.98	94.5	6.5008	58.0019
2025	11	10	14	30	0	14	0.1	1	28.25	95.9	6.5008	60.5892
2025	11	10	14	40	0	14	0.1	1	27.3	94.8	6.5008	58.6486
2025	11	10	14	50	0	14	0.1	1	26.53	95.6	6.5008	56.9236
2025	11	10	15	0	0	14	0.1	1	27.08	98.3	6.5008	57.7861
2025	11	10	15	10	0	13.8	0.1	1	27.96	96.2	6.5008	59.9422
2025	11	10	15	20	0	13.8	0.1	1	27.52	97.3	6.5008	58.8641
2025	11	10	15	30	0	13.8	0.1	1	28.19	94.5	6.5008	60.589
2025	11	10	15	40	0	13.6	0.1	1	27.58	94.4	6.5008	59.2953
2025	11	10	15	50	0	13.6	0.1	1	28.98	94.4	6.5008	62.3139

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	10	16	0	0	13.4	0.1	1	28.55	95.8	6.5008	61.2358
2025	11	10	16	10	0	13.4	0.1	1	28.39	94.4	6.5008	61.0202
2025	11	10	16	20	0	13.2	0.1	1	28.19	94.7	6.5069	60.6481
2025	11	10	16	30	0	13.2	0.1	1	27.32	95.5	6.5069	58.7057
2025	11	10	16	40	0	13.2	0.1	1	28.45	95.9	6.5069	61.0798
2025	11	10	16	50	0	12.6	0.1	1	27.15	93.6	6.5069	58.4898
2025	11	10	17	0	0	12	0.1	1	28.25	93.4	6.5069	60.8639
2025	11	10	17	10	0	11.8	0.1	1	28.14	93.1	6.5069	60.6481
2025	11	10	17	20	0	12.2	0.1	1	27.68	94.4	6.5069	59.5689
2025	11	10	17	30	0	12.2	0.1	1	28.46	93.6	6.5069	61.2955
2025	11	10	17	40	0	11.8	0.1	1	27.74	92.9	6.5069	59.7847
2025	11	10	17	50	0	11.8	0.1	1	28.45	95.9	6.5069	61.0797
2025	11	10	18	0	0	11.8	0.1	1	28.08	94.3	6.5069	60.4322
2025	11	10	18	10	0	11.8	0.1	1	27.81	95.2	6.5069	59.7848
2025	11	10	18	20	0	12.2	0.1	1	27.38	94.4	6.5069	58.9214
2025	11	10	18	30	0	12	0.1	1	28.58	94.2	6.5069	61.5114
2025	11	10	18	40	0	12	0.1	1	28.4	96.9	6.513	60.9234
2025	11	10	18	50	0	12	0.1	1	27.76	93.7	6.513	59.8432
2025	11	10	19	0	0	12	0.1	1	27.46	93.8	6.513	59.1951
2025	11	10	19	10	0	12	0.1	1	28.12	92.2	6.513	60.7074
2025	11	10	19	20	0	12	0.1	1	28.25	95.9	6.513	60.7074
2025	11	10	19	30	0	12	0.1	1	28.24	95.7	6.513	60.7074
2025	11	10	19	40	0	12	0.1	1	27.3	94.8	6.513	58.7631
2025	11	10	19	50	0	12	0.1	1	28.32	95.3	6.5191	60.983
2025	11	10	20	0	0	12	0.1	1	28.13	92.9	6.5191	60.7668
2025	11	10	20	10	0	12	0.1	1	29.34	93.1	6.5191	63.3618
2025	11	10	20	20	0	12	0.1	1	28.26	93.7	6.5191	60.9831
2025	11	10	20	30	0	12	0.1	1	27.53	92.7	6.5191	59.4693
2025	11	10	20	40	0	12	0.1	1	27.53	92.7	6.5191	59.4694
2025	11	10	20	50	0	12	0.1	1	27.35	93.4	6.5191	59.0369
2025	11	10	21	0	0	12	0.1	1	28.36	93.8	6.5191	61.1994
2025	11	10	21	10	0	12	0.1	1	29	94.7	6.5191	62.497
2025	11	10	21	20	0	12	0.1	1	28.07	94.1	6.5252	60.6098
2025	11	10	21	30	0	12	0.1	1	28.21	95.1	6.5252	60.8263
2025	11	10	21	40	0	12	0.1	1	27.72	92.1	6.5313	60.0188
2025	11	10	21	50	0	12	0.1	1	28.05	93.5	6.5374	60.7279
2025	11	10	22	0	0	12	0.1	1	28.11	91.6	6.5434	61.004
2025	11	10	22	10	0	12	0.1	1	28.87	94	6.5434	62.5238
2025	11	10	22	20	0	12	0.1	1	28.73	95.4	6.5434	62.0896
2025	11	10	22	30	0	12	0.1	1	29.62	92.3	6.5434	64.2606
2025	11	10	22	40	0	12	0.1	1	28.65	93.4	6.5434	62.0896
2025	11	10	22	50	0	12	0.1	1	29.05	93.4	6.5434	62.9581
2025	11	10	23	0	0	12	0.1	1	28.23	92.6	6.5495	61.2808
2025	11	10	23	10	0	12	0.1	1	28.04	93.1	6.5495	60.8462
2025	11	10	23	20	0	12	0.1	1	27.48	94.4	6.5495	59.5424
2025	11	10	23	30	0	12	0.1	1	28.51	91.6	6.5495	61.9328
2025	11	10	23	40	0	12	0.1	1	28.41	95	6.5495	61.4982
2025	11	10	23	50	0	12	0.1	1	27.73	92.7	6.5495	60.1944

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	11	0	0	0	12	0.1	1	28.64	93.2	6.5495	62.1502
2025	11	11	0	10	0	12	0.1	1	28.3	94.9	6.5495	61.281
2025	11	11	0	20	0	12	0.1	1	28.77	94	6.5495	62.3675
2025	11	11	0	30	0	12	0.1	1	28.16	93.7	6.5495	61.0637
2025	11	11	0	40	0	12	0.1	1	28.15	93.5	6.5495	61.0637
2025	11	11	0	50	0	12	0.1	1	27.34	93.1	6.5495	59.3253
2025	11	11	1	0	0	12	0.1	1	27.71	95.2	6.5495	59.9772
2025	11	11	1	10	0	12	0.1	1	29.01	94.9	6.5495	62.8023
2025	11	11	1	20	0	11.8	0.1	1	29.37	93.9	6.5556	63.7333
2025	11	11	1	30	0	11.8	0.1	1	28.03	92.7	6.5495	60.8466
2025	11	11	1	40	0	11.8	0.1	1	28.21	91.8	6.5495	61.2812
2025	11	11	1	50	0	11.8	0.1	1	28.05	93.5	6.5556	60.9056
2025	11	11	2	0	0	11.8	0.1	1	28.13	92.4	6.5556	61.1232
2025	11	11	2	10	0	11.8	0.1	1	28.39	94.6	6.5556	61.5583
2025	11	11	2	20	0	11.8	0.1	1	27.58	94.4	6.5556	59.8181
2025	11	11	2	30	0	11.8	0.1	1	27.36	93.8	6.5556	59.3831
2025	11	11	2	40	0	11.8	0.1	1	29.71	91.5	6.5556	64.6036
2025	11	11	2	50	0	11.8	0.1	1	28.21	95.1	6.5556	61.1233
2025	11	11	3	0	0	11.8	0.1	1	27.97	96.4	6.5556	60.4708
2025	11	11	3	10	0	11.8	0.1	1	28.05	93.5	6.5556	60.9058
2025	11	11	3	20	0	11.8	0.1	1	28.25	93.4	6.5556	61.3409
2025	11	11	3	30	0	11.8	0.1	1	28.35	93.4	6.5556	61.5584
2025	11	11	3	40	0	11.8	0.1	1	27.63	92.5	6.5556	60.0358
2025	11	11	3	50	0	11.8	0.1	1	28.16	93.7	6.5556	61.1234
2025	11	11	4	0	0	11.8	0.1	1	28.46	96.1	6.5556	61.5585
2025	11	11	4	10	0	11.8	0.1	1	27.45	93.6	6.5556	59.6008
2025	11	11	4	20	0	11.8	0.1	1	27.84	93.1	6.5556	60.4709
2025	11	11	4	30	0	11.8	0.1	1	28.36	93.8	6.5556	61.5585
2025	11	11	4	40	0	11.8	0.1	1	28.56	93.8	6.5556	61.9936
2025	11	11	4	50	0	11.8	0.1	1	28.35	93.2	6.5556	61.5586
2025	11	11	5	0	0	11.8	0.1	1	28.85	93.4	6.5556	62.6462
2025	11	11	5	10	0	11.8	0.1	1	28.31	91.6	6.5556	61.5586
2025	11	11	5	20	0	11.8	0.1	1	26.86	93.8	6.5556	58.2958
2025	11	11	5	30	0	11.8	0.1	1	28.22	92.2	6.5556	61.3411
2025	11	11	5	40	0	11.8	0.1	1	28.79	94.6	6.5556	62.4287
2025	11	11	5	50	0	11.8	0.1	1	27.64	93.1	6.5556	60.036
2025	11	11	6	0	0	11.8	0.1	1	28.44	93	6.5556	61.7762
2025	11	11	6	10	0	11.8	0.1	1	28.43	95.4	6.5617	61.6184
2025	11	11	6	20	0	11.8	0.1	1	27.57	94	6.5617	59.8765
2025	11	11	6	30	0	11.8	0.1	1	28.87	94	6.5617	62.7071
2025	11	11	6	40	0	11.6	0.1	1	27.57	94	6.5617	59.8765
2025	11	11	6	50	0	11.6	0.1	1	27.77	96.4	6.5617	60.0943
2025	11	11	7	0	0	11.6	0.1	1	29.04	95.5	6.5617	62.9248
2025	11	11	7	10	0	11.6	0.1	1	28.19	96.7	6.5617	60.9653
2025	11	11	7	20	0	11.6	0.1	1	29.02	92	6.5617	63.1426
2025	11	11	7	30	0	11.6	0.1	1	28.29	94.5	6.5617	61.4008
2025	11	11	7	40	0	11.6	0.1	1	28.76	93.6	6.5617	62.4894
2025	11	11	7	50	0	11.6	0.1	1	28.19	94.7	6.5617	61.1831

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	11	8	0	0	11.6	0.1	1	28.27	94.1	6.5617	61.4008
2025	11	11	8	10	0	11.8	0.1	1	28.18	94.3	6.5617	61.1831
2025	11	11	8	20	0	12	0.1	1	28.68	94.2	6.5617	62.2718
2025	11	11	8	30	0	12.4	0.1	1	28.23	92.6	6.5617	61.4008
2025	11	11	8	40	0	12.4	0.1	1	28.29	94.7	6.5617	61.4008
2025	11	11	8	50	0	12.8	0.1	1	28.64	93.2	6.5617	62.2718
2025	11	11	9	0	0	12.6	0.1	1	27.44	93.1	6.5617	59.659
2025	11	11	9	10	0	12.6	0.1	1	27.55	93.3	6.5617	59.8767
2025	11	11	9	20	0	12.8	0.1	1	28.16	96.1	6.5617	60.9653
2025	11	11	9	30	0	12.8	0.1	1	27.86	93.9	6.5617	60.5299
2025	11	11	9	40	0	12.8	0.1	1	26.96	96.2	6.5617	58.3525
2025	11	11	9	50	0	12.6	0.1	1	27.08	96.6	6.5617	58.5702
2025	11	11	10	0	0	12.8	0.1	1	28.29	94.7	6.5617	61.4008
2025	11	11	10	10	0	12.8	0.1	1	28.91	95	6.5678	62.7679
2025	11	11	10	20	0	13	0.1	1	27.86	96.2	6.5678	60.3704
2025	11	11	10	30	0	13	0.1	1	27.47	94.2	6.5678	59.7166
2025	11	11	10	40	0	13	0.1	1	27.86	93.9	6.5617	60.5297
2025	11	11	10	50	0	13.4	0.1	1	26.77	94.1	6.5678	58.1909
2025	11	11	11	0	0	13.4	0.1	1	28.44	97.5	6.5617	61.4006
2025	11	11	11	10	0	14.2	0.1	1	27.47	94.2	6.5617	59.6587
2025	11	11	11	20	0	14.2	0.1	1	28.47	94	6.5617	61.836
2025	11	11	11	30	0	14.2	0.1	1	27.64	95.8	6.5678	59.9343
2025	11	11	11	40	0	14.2	0.1	1	27.2	94.9	6.5678	59.0625
2025	11	11	11	50	0	14.2	0.1	1	27.81	95.2	6.5678	60.3701
2025	11	11	12	0	0	14.2	0.1	1	28.12	97.2	6.5678	60.806
2025	11	11	12	10	0	14.2	0.1	1	27.46	98	6.5678	59.2803
2025	11	11	12	20	0	14.2	0.1	1	28.25	95.9	6.5678	61.2418
2025	11	11	12	30	0	14	0.1	1	26.48	96.7	6.5678	57.3188
2025	11	11	12	40	0	13.4	0.1	1	26.54	95.8	6.5678	57.5367
2025	11	11	12	50	0	13.8	0.1	1	27.58	98.1	6.5678	59.4981
2025	11	11	13	0	0	14.2	0.1	1	27.5	96.9	6.5678	59.4981
2025	11	11	13	10	0	14.2	0.1	1	27.28	98.2	6.5678	58.8442
2025	11	11	13	20	0	14	0.1	1	27.82	97.2	6.5678	60.1518
2025	11	11	13	30	0	13.8	0.1	1	28.33	95.5	6.5678	61.4594
2025	11	11	13	40	0	13.8	0.1	1	27.46	96.3	6.5678	59.4979
2025	11	11	13	50	0	13.8	0.1	1	27.82	95.4	6.5739	60.428
2025	11	11	14	0	0	13.8	0.1	1	27.37	98	6.5739	59.1191
2025	11	11	14	10	0	13	0.1	1	27.78	96.6	6.5739	60.2098
2025	11	11	14	20	0	13	0.1	1	27.7	96.8	6.5739	59.9916
2025	11	11	14	30	0	13.2	0.1	1	27.51	97.1	6.5739	59.5553
2025	11	11	14	40	0	13.2	0.1	1	27.55	97.7	6.5739	59.5553
2025	11	11	14	50	0	12.8	0.1	1	27.31	98.6	6.5739	58.9008
2025	11	11	15	0	0	13.4	0.1	1	25.85	96.2	6.5739	56.0648
2025	11	11	15	10	0	12.6	0.1	1	26.97	96.4	6.5739	58.4644
2025	11	11	15	20	0	12.6	0.1	1	26.38	98.3	6.5739	56.9374
2025	11	11	15	30	0	12.6	0.1	1	26.82	100.1	6.5739	57.5918
2025	11	11	15	40	0	12.6	0.1	1	26.49	99.8	6.5739	56.9373
2025	11	11	15	50	0	12.6	0.1	1	27.2	101	6.5739	58.2462

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	11	16	0	0	12.6	0.1	1	25.42	101.6	6.58	54.372
2025	11	11	16	10	0	12.6	0.1	1	25.17	99.8	6.58	54.1536
2025	11	11	16	20	0	12.4	0.1	1	25.26	101	6.58	54.1536
2025	11	11	16	30	0	12.4	0.1	1	26.19	98.6	6.58	56.5556
2025	11	11	16	40	0	12.2	0.1	1	26.55	101.7	6.58	56.7739
2025	11	11	16	50	0	12.2	0.1	1	25.84	99.4	6.58	55.6821
2025	11	11	17	0	0	12.2	0.1	1	25.99	101.1	6.58	55.6821
2025	11	11	17	10	0	12.2	0.1	1	26.02	99.1	6.58	56.1188
2025	11	11	17	20	0	12.2	0.1	1	26.49	98.5	6.58	57.2106
2025	11	11	17	30	0	12.2	0.1	1	27.18	98.2	6.58	58.7392
2025	11	11	17	40	0	12.2	0.1	1	27.52	97.3	6.58	59.6126
2025	11	11	17	50	0	12.2	0.1	1	26.99	96.8	6.58	58.5208
2025	11	11	18	0	0	12	0.1	1	26.94	97.7	6.58	58.3025
2025	11	11	18	10	0	12	0.1	1	26.96	96.2	6.58	58.5208
2025	11	11	18	20	0	12	0.1	1	27.03	95.5	6.58	58.7392
2025	11	11	18	30	0	12	0.1	1	28.04	95.7	6.58	60.9228
2025	11	11	18	40	0	12	0.1	1	27.64	95.8	6.58	60.0494
2025	11	11	18	50	0	12	0.1	1	25.9	97.1	6.58	56.1189
2025	11	11	19	0	0	12	0.1	1	26.77	94.3	6.58	58.3025
2025	11	11	19	10	0	12	0.1	1	27.27	98	6.5861	59.0145
2025	11	11	19	20	0	12	0.1	1	27.46	98	6.5861	59.4517
2025	11	11	19	30	0	12	0.1	1	27.77	99.3	6.5861	59.8888
2025	11	11	19	40	0	12	0.1	1	28.21	98.6	6.5861	60.9817
2025	11	11	19	50	0	12	0.1	1	27.37	98	6.5861	59.2331
2025	11	11	20	0	0	12	0.1	1	26.37	96.5	6.5861	57.266
2025	11	11	20	10	0	12	0.1	1	28.23	95.5	6.5861	61.4189
2025	11	11	20	20	0	12	0.1	1	26.9	97	6.5861	58.3589
2025	11	11	20	30	0	12	0.1	1	26.88	96.6	6.5861	58.3589
2025	11	11	20	40	0	12	0.1	1	27.73	95.6	6.5861	60.326
2025	11	11	20	50	0	12	0.1	1	28.35	95.9	6.5861	61.6375
2025	11	11	21	0	0	12	0.1	1	27.05	95.9	6.5861	58.7961
2025	11	11	21	10	0	12	0.1	1	27.96	93.9	6.5861	60.9818
2025	11	11	21	20	0	12	0.1	1	28.64	95.6	6.5861	62.2932
2025	11	11	21	30	0	12	0.1	1	27.19	94.6	6.5861	59.2332
2025	11	11	21	40	0	12	0.1	1	27.87	96.4	6.5861	60.5447
2025	11	11	21	50	0	12	0.1	1	28.34	93	6.5861	61.8561
2025	11	11	22	0	0	12	0.1	1	28.12	95.3	6.5861	61.2004
2025	11	11	22	10	0	12	0.1	1	27.96	93.9	6.5861	60.9819
2025	11	11	22	20	0	12	0.1	1	27.64	95.8	6.5861	60.1076
2025	11	11	22	30	0	12	0.1	1	27.4	94.8	6.5861	59.6704
2025	11	11	22	40	0	12	0.1	1	28.41	95	6.5922	61.9159
2025	11	11	22	50	0	12	0.1	1	27.88	94.3	6.5922	60.822
2025	11	11	23	0	0	12	0.1	1	28.49	94.4	6.5922	62.1347
2025	11	11	23	10	0	12	0.1	1	27.79	94.5	6.5922	60.6032
2025	11	11	23	20	0	12	0.1	1	27.12	95.3	6.5922	59.0717
2025	11	11	23	30	0	12	0.1	1	28.66	93.6	6.5922	62.5723
2025	11	11	23	40	0	12	0.1	1	28.44	95.7	6.5983	61.9756
2025	11	11	23	50	0	11.8	0.1	1	28.06	93.7	6.5983	61.3186

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	12	0	0	0	11.8	0.1	1	27.85	93.5	6.5983	60.8807
2025	11	12	0	10	0	11.8	0.1	1	29.64	95.6	6.5983	64.6036
2025	11	12	0	20	0	11.8	0.1	1	28.6	94.8	6.5983	62.4137
2025	11	12	0	30	0	11.8	0.1	1	28.52	95.2	6.5983	62.1947
2025	11	12	0	40	0	11.8	0.1	1	27.43	95.6	6.5983	59.7858
2025	11	12	0	50	0	11.8	0.1	1	27.36	96.3	6.5983	59.5668
2025	11	12	1	0	0	11.8	0.1	1	27.88	96.6	6.6044	60.7202
2025	11	12	1	10	0	11.8	0.1	1	28.51	95	6.5983	62.1947
2025	11	12	1	20	0	11.8	0.1	1	28.21	95.1	6.5983	61.5378
2025	11	12	1	30	0	11.8	0.1	1	28.77	94	6.5983	62.8518
2025	11	12	1	40	0	11.8	0.1	1	28.63	92.6	6.5983	62.6328
2025	11	12	1	50	0	11.8	0.1	1	29.62	95.2	6.5983	64.6038
2025	11	12	2	0	0	11.8	0.1	1	27.83	92.5	6.6044	60.9395
2025	11	12	2	10	0	11.8	0.1	1	29.07	96.1	6.5983	63.2898
2025	11	12	2	20	0	11.8	0.1	1	27.65	96	6.5983	60.2239
2025	11	12	2	30	0	11.8	0.1	1	28.6	98.2	6.5922	61.9162
2025	11	12	2	40	0	11.8	0.1	1	27.4	96.9	6.5983	59.5669
2025	11	12	2	50	0	11.8	0.1	1	27.8	96.8	6.5922	60.3847
2025	11	12	3	0	0	11.8	0.1	1	27.38	96.5	6.5983	59.5669
2025	11	12	3	10	0	11.8	0.1	1	27.62	97.3	6.5983	60.0049
2025	11	12	3	20	0	11.8	0.1	1	29.08	94.3	6.5922	63.4477
2025	11	12	3	30	0	11.8	0.1	1	27.94	92.9	6.5922	61.0411
2025	11	12	3	40	0	11.8	0.1	1	28.39	94.6	6.5922	61.9162
2025	11	12	3	50	0	11.8	0.1	1	28.43	92.8	6.5922	62.135
2025	11	12	4	0	0	11.8	0.1	1	28.18	94.3	6.5922	61.4786
2025	11	12	4	10	0	11.8	0.1	1	29.31	94.9	6.5922	63.8853
2025	11	12	4	20	0	11.8	0.1	1	28.72	92.2	6.5983	62.8519
2025	11	12	4	30	0	11.8	0.1	1	28	94.9	6.5922	61.0411
2025	11	12	4	40	0	11.8	0.1	1	27.82	92.1	6.5922	60.8223
2025	11	12	4	50	0	11.8	0.1	1	29.3	94.7	6.5983	63.9468
2025	11	12	5	0	0	11.8	0.1	1	29.74	95.6	6.5922	64.7604
2025	11	12	5	10	0	11.8	0.1	1	27.45	93.6	6.5922	59.9471
2025	11	12	5	20	0	11.8	0.1	1	28.61	95	6.5922	62.3538
2025	11	12	5	30	0	11.8	0.1	1	27.92	92.3	6.5922	61.0411
2025	11	12	5	40	0	11.8	0.1	1	28.03	92.9	6.5922	61.2598
2025	11	12	5	50	0	11.8	0.1	1	27.84	93.1	6.5922	60.8223
2025	11	12	6	0	0	11.8	0.1	1	27.96	93.9	6.5922	61.041
2025	11	12	6	10	0	11.8	0.1	1	27.95	93.5	6.5922	61.041
2025	11	12	6	20	0	11.6	0.1	1	29.3	94.7	6.5983	63.9468
2025	11	12	6	30	0	11.6	0.1	1	29.84	95.6	6.5983	65.0418
2025	11	12	6	40	0	11.6	0.1	1	29.03	92.8	6.5922	63.4477
2025	11	12	6	50	0	11.6	0.1	1	28.67	94	6.5922	62.5725
2025	11	12	7	0	0	11.6	0.1	1	29.6	94.7	6.5922	64.5416
2025	11	12	7	10	0	11.6	0.1	1	28.98	94.4	6.5922	63.2289
2025	11	12	7	20	0	11.6	0.1	1	29.84	93.1	6.5922	65.198
2025	11	12	7	30	0	11.6	0.1	1	27.84	93.1	6.5922	60.8223
2025	11	12	7	40	0	11.6	0.1	1	28.07	94.1	6.5922	61.2598
2025	11	12	7	50	0	11.6	0.1	1	28.41	95	6.5861	61.8565

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	12	8	0	0	11.6	0.1	1	28.05	93.3	6.5861	61.2008
2025	11	12	8	10	0	11.6	0.1	1	28.49	94.6	6.5861	62.0751
2025	11	12	8	20	0	11.8	0.1	1	28.56	93.8	6.5861	62.2937
2025	11	12	8	30	0	11.8	0.1	1	28.02	92	6.5861	61.2008
2025	11	12	8	40	0	11.8	0.1	1	28.06	93.9	6.58	61.1418
2025	11	12	8	50	0	11.8	0.1	1	27.49	94.6	6.5861	59.8893
2025	11	12	9	0	0	11.8	0.1	1	29.21	94.9	6.5861	63.6051
2025	11	12	9	10	0	11.8	0.1	1	28.12	95.3	6.58	61.1417
2025	11	12	9	20	0	11.8	0.1	1	27.83	92.5	6.58	60.705
2025	11	12	9	30	0	11.8	0.1	1	28.08	94.3	6.58	61.1417
2025	11	12	9	40	0	11.8	0.1	1	29.17	93.9	6.58	63.5437
2025	11	12	9	50	0	11.8	0.1	1	29.18	94.1	6.58	63.5437
2025	11	12	10	0	0	12	0.1	1	28.19	94.7	6.58	61.36
2025	11	12	10	10	0	12.2	0.1	1	28.15	93.3	6.58	61.36
2025	11	12	10	20	0	12.4	0.1	1	29.36	93.5	6.58	63.9804
2025	11	12	10	30	0	12.4	0.1	1	28.6	94.8	6.58	62.2334
2025	11	12	10	40	0	12.6	0.1	1	27.86	93.7	6.58	60.7049
2025	11	12	10	50	0	12.4	0.1	1	27.83	92.7	6.58	60.7049
2025	11	12	11	0	0	12.4	0.1	1	29.33	92.5	6.58	63.9803
2025	11	12	11	10	0	12.4	0.1	1	28.42	95.2	6.58	61.7967
2025	11	12	11	20	0	12.4	0.1	1	28.53	92.4	6.58	62.2334
2025	11	12	11	30	0	12.4	0.1	1	28.58	94.2	6.58	62.2334
2025	11	12	11	40	0	12.4	0.1	1	28.88	94.2	6.5861	62.9491
2025	11	12	11	50	0	12.4	0.1	1	29.06	93.6	6.5861	63.3863
2025	11	12	12	0	0	12.4	0.1	1	28.49	94.4	6.5861	62.0748
2025	11	12	12	10	0	12.6	0.1	1	27.56	93.7	6.5861	60.1076
2025	11	12	12	20	0	12.6	0.1	1	28.48	94.2	6.5861	62.0748
2025	11	12	12	30	0	13	0.1	1	28.66	96	6.5861	62.2933
2025	11	12	12	40	0	12.8	0.1	1	29.07	93.9	6.5861	63.3861
2025	11	12	12	50	0	12.8	0.1	1	28.73	92.8	6.5861	62.7304
2025	11	12	13	0	0	13	0.1	1	27.3	94.8	6.5861	59.4518
2025	11	12	13	10	0	13	0.1	1	29.28	94.3	6.58	63.7616
2025	11	12	13	20	0	13	0.1	1	28.67	96.2	6.5861	62.2932
2025	11	12	13	30	0	13	0.1	1	27.71	97	6.5861	60.1074
2025	11	12	13	40	0	13	0.1	1	27.47	94	6.5922	59.9466
2025	11	12	13	50	0	13	0.1	1	28.76	96	6.5861	62.5116
2025	11	12	14	0	0	13.2	0.1	1	28.54	97.4	6.5861	61.8558
2025	11	12	14	10	0	13.2	0.1	1	28.32	95.3	6.5922	61.6967
2025	11	12	14	20	0	13.6	0.1	1	28.36	93.6	6.5861	61.8558
2025	11	12	14	30	0	13.6	0.1	1	28.9	94.8	6.5861	62.9486
2025	11	12	14	40	0	13.6	0.1	1	28.84	95.6	6.5861	62.73
2025	11	12	14	50	0	14.2	0.1	1	27.91	95.1	6.5861	60.7628
2025	11	12	15	0	0	14	0.1	1	28.05	93.5	6.5861	61.1999
2025	11	12	15	10	0	14	0.1	1	28.31	95.1	6.5861	61.637
2025	11	12	15	20	0	13.8	0.1	1	28.35	95.9	6.5861	61.637
2025	11	12	15	30	0	14	0.1	1	27.41	95.2	6.5861	59.6698
2025	11	12	15	40	0	13.8	0.1	1	28.85	93.4	6.5861	62.9484
2025	11	12	15	50	0	13.8	0.1	1	28.6	96.8	6.5861	62.0741

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	12	16	0	0	13.6	0.1	1	29.4	96.6	6.5861	63.8226
2025	11	12	16	10	0	13.6	0.1	1	27.87	96.4	6.5861	60.5441
2025	11	12	16	20	0	13.4	0.1	1	27.54	95.8	6.5861	59.8883
2025	11	12	16	30	0	13.4	0.1	1	27.22	95.5	6.5861	59.2326
2025	11	12	16	40	0	13.2	0.1	1	28.29	94.7	6.5861	61.6369
2025	11	12	16	50	0	13	0.1	1	28.76	96	6.5861	62.5112
2025	11	12	17	0	0	11.8	0.1	1	27.98	94.3	6.5861	60.9812
2025	11	12	17	10	0	11.6	0.1	1	29.4	94.7	6.5861	64.0412
2025	11	12	17	20	0	12.2	0.1	1	28.98	96.3	6.5861	62.9483
2025	11	12	17	30	0	12.2	0.1	1	29.34	95.7	6.5861	63.8226
2025	11	12	17	40	0	12.2	0.1	1	29.57	94.1	6.5861	64.4783
2025	11	12	17	50	0	12.2	0.1	1	27.84	95.8	6.5861	60.544
2025	11	12	18	0	0	12.2	0.1	1	29.01	94.9	6.5861	63.1669
2025	11	12	18	10	0	12.2	0.1	1	29.14	93.1	6.5861	63.604
2025	11	12	18	20	0	12.2	0.1	1	29.46	93.7	6.5861	64.2598
2025	11	12	18	30	0	12.2	0.1	1	27.91	95.1	6.5861	60.7626
2025	11	12	18	40	0	12.2	0.1	1	29.54	95.6	6.5861	64.2598
2025	11	12	18	50	0	12	0.1	1	29.38	94.1	6.5861	64.0412
2025	11	12	19	0	0	12	0.1	1	29.06	93.6	6.5861	63.3855
2025	11	12	19	10	0	12	0.1	1	28.98	94.2	6.5861	63.167
2025	11	12	19	20	0	12	0.1	1	29.04	95.5	6.5861	63.167
2025	11	12	19	30	0	12	0.1	1	29.4	94.7	6.5861	64.0413
2025	11	12	19	40	0	12	0.1	1	28.11	95.1	6.5861	61.1999
2025	11	12	19	50	0	12	0.1	1	28.46	93.6	6.5861	62.0742
2025	11	12	20	0	0	12	0.1	1	29.02	97.1	6.5861	62.9485
2025	11	12	20	10	0	12	0.1	1	28.5	94.8	6.5861	62.0742
2025	11	12	20	20	0	12	0.1	1	29.28	94.1	6.5861	63.8228
2025	11	12	20	30	0	12	0.1	1	28.85	93.4	6.5861	62.9485
2025	11	12	20	40	0	12	0.1	1	28.65	93.4	6.5861	62.5114
2025	11	12	20	50	0	12	0.1	1	28.2	94.9	6.5861	61.4186
2025	11	12	21	0	0	12	0.1	1	29.07	93.9	6.5861	63.3857
2025	11	12	21	10	0	12	0.1	1	28.88	94.4	6.5861	62.9486
2025	11	12	21	20	0	12	0.1	1	28.21	91.4	6.5861	61.6372
2025	11	12	21	30	0	12	0.1	1	27.96	93.7	6.5861	60.9815
2025	11	12	21	40	0	12	0.1	1	28.28	94.3	6.5861	61.6372
2025	11	12	21	50	0	12	0.1	1	27.81	91.9	6.5861	60.7629
2025	11	12	22	0	0	12	0.1	1	29.05	93.4	6.5861	63.3858
2025	11	12	22	10	0	12	0.1	1	29.96	93.6	6.5861	65.353
2025	11	12	22	20	0	12	0.1	1	27.73	92.7	6.5861	60.5444
2025	11	12	22	30	0	12	0.1	1	27.93	92.7	6.5861	60.9816
2025	11	12	22	40	0	12	0.1	1	28.35	93.4	6.5861	61.8559
2025	11	12	22	50	0	12	0.1	1	29.17	93.9	6.5861	63.6045
2025	11	12	23	0	0	12	0.1	1	29.48	94.3	6.5861	64.2602
2025	11	12	23	10	0	12	0.1	1	28.55	93.4	6.5861	62.2931
2025	11	12	23	20	0	12	0.1	1	28.73	92.4	6.5861	62.7302
2025	11	12	23	30	0	12	0.1	1	29.55	93.5	6.5861	64.4788
2025	11	12	23	40	0	12	0.1	1	28.84	95.6	6.5861	62.7303
2025	11	12	23	50	0	12	0.1	1	28.54	93	6.5861	62.2931

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	13	0	0	0	12	0.1	1	28.71	91.6	6.5861	62.7303
2025	11	13	0	10	0	12	0.1	1	27.91	95.1	6.5861	60.7631
2025	11	13	0	20	0	12	0.1	1	28.25	93.2	6.5861	61.6375
2025	11	13	0	30	0	12	0.1	1	27.96	93.9	6.5861	60.9818
2025	11	13	0	40	0	12	0.1	1	29.05	93.4	6.5861	63.3861
2025	11	13	0	50	0	12	0.1	1	28.93	92.8	6.5861	63.1675
2025	11	13	1	0	0	12	0.1	1	27.86	93.7	6.5922	60.8218
2025	11	13	1	10	0	12	0.1	1	28.23	92.6	6.5861	61.6375
2025	11	13	1	20	0	12	0.1	1	27.81	95.2	6.5861	60.5447
2025	11	13	1	30	0	12	0.1	1	28.38	94.2	6.5861	61.8561
2025	11	13	1	40	0	12	0.1	1	27.95	93.3	6.5922	61.0407
2025	11	13	1	50	0	12	0.1	1	27.47	94	6.5922	59.9468
2025	11	13	2	0	0	11.8	0.1	1	26.95	93.4	6.5922	58.8529
2025	11	13	2	10	0	11.8	0.1	1	27.45	96.1	6.5922	59.728
2025	11	13	2	20	0	11.8	0.1	1	29.42	95.1	6.5922	64.1037
2025	11	13	2	30	0	11.8	0.1	1	27.67	96.4	6.5983	60.2236
2025	11	13	2	40	0	11.8	0.1	1	27.59	96.7	6.5983	60.0046
2025	11	13	2	50	0	11.8	0.1	1	28.85	95.8	6.5983	62.8516
2025	11	13	3	0	0	11.8	0.1	1	28.01	95.1	6.5983	61.0996
2025	11	13	3	10	0	11.8	0.1	1	28.98	94.4	6.5983	63.2896
2025	11	13	3	20	0	11.8	0.1	1	27.56	93.7	6.5983	60.2237
2025	11	13	3	30	0	11.8	0.1	1	27.81	95.2	6.5983	60.6617
2025	11	13	3	40	0	11.8	0.1	1	27.91	95.1	6.5983	60.8807
2025	11	13	3	50	0	11.8	0.1	1	28.5	94.8	6.5983	62.1946
2025	11	13	4	0	0	11.8	0.1	1	29.6	94.7	6.5983	64.6036
2025	11	13	4	10	0	11.8	0.1	1	29.21	91.2	6.6044	64.0082
2025	11	13	4	20	0	11.8	0.1	1	28.74	95.6	6.6044	62.693
2025	11	13	4	30	0	11.8	0.1	1	29.01	94.9	6.6044	63.3506
2025	11	13	4	40	0	11.8	0.1	1	27.21	95.1	6.6044	59.4049
2025	11	13	4	50	0	11.8	0.1	1	27.47	94	6.6044	60.0625
2025	11	13	5	0	0	11.8	0.1	1	28.33	92.6	6.6044	62.0354
2025	11	13	5	10	0	11.8	0.1	1	28.85	93.4	6.6044	63.1314
2025	11	13	5	20	0	11.8	0.1	1	29.3	94.7	6.6044	64.0083
2025	11	13	5	30	0	11.8	0.1	1	28.57	94	6.6044	62.4738
2025	11	13	5	40	0	11.8	0.1	1	28.63	92.6	6.6044	62.6931
2025	11	13	5	50	0	11.8	0.1	1	28.36	93.6	6.6044	62.0354
2025	11	13	6	0	0	11.8	0.1	1	28.89	94.6	6.6044	63.1315
2025	11	13	6	10	0	11.8	0.1	1	30.07	93.8	6.6044	65.762
2025	11	13	6	20	0	11.8	0.1	1	28.52	95.2	6.6044	62.2547
2025	11	13	6	30	0	11.8	0.1	1	28.55	93.4	6.6044	62.4739
2025	11	13	6	40	0	11.8	0.1	1	28.74	93.2	6.6044	62.9123
2025	11	13	6	50	0	11.8	0.1	1	28.16	93.7	6.6044	61.597
2025	11	13	7	0	0	11.8	0.1	1	28.54	93	6.6044	62.4739
2025	11	13	7	10	0	11.8	0.1	1	28.11	91.8	6.6044	61.5971
2025	11	13	7	20	0	11.6	0.1	1	28.91	91.6	6.6044	63.3507
2025	11	13	7	30	0	11.6	0.1	1	28.1	90.8	6.6044	61.5971
2025	11	13	7	40	0	11.8	0.1	1	27.86	93.7	6.5983	60.8808
2025	11	13	7	50	0	11.8	0.1	1	29.03	95.3	6.6044	63.3507

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	13	8	0	0	11.8	0.1	1	28.22	95.3	6.6044	61.5971
2025	11	13	8	10	0	11.8	0.1	1	27.74	92.9	6.5983	60.6618
2025	11	13	8	20	0	12	0.1	1	27.99	94.5	6.5922	61.041
2025	11	13	8	30	0	12.4	0.1	1	29.19	94.5	6.5922	63.6664
2025	11	13	8	40	0	12.8	0.1	1	28.41	95	6.5861	61.8565
2025	11	13	8	50	0	13.2	0.1	1	28.39	94.6	6.5861	61.8564
2025	11	13	9	0	0	13.8	0.1	1	29.18	94.1	6.5861	63.605
2025	11	13	9	10	0	14	0.1	1	29.37	93.9	6.5922	64.1039
2025	11	13	9	20	0	13	0.1	1	29.4	94.7	6.5861	64.0422
2025	11	13	9	30	0	12.6	0.1	1	28.58	94.4	6.58	62.2335
2025	11	13	9	40	0	12	0.1	1	28.31	95.1	6.58	61.5784
2025	11	13	9	50	0	12	0.1	1	27.71	95.2	6.58	60.2682
2025	11	13	10	0	0	12	0.1	1	28.68	96.4	6.58	62.2334
2025	11	13	10	10	0	12.2	0.1	1	29.1	94.7	6.58	63.3252
2025	11	13	10	20	0	12.4	0.1	1	28.63	95.4	6.58	62.2334
2025	11	13	10	30	0	12.4	0.1	1	29.06	95.9	6.5739	63.0459
2025	11	13	10	40	0	12.4	0.1	1	28.29	94.5	6.5739	61.5188
2025	11	13	10	50	0	12.4	0.1	1	29.26	96.1	6.5739	63.4821
2025	11	13	11	0	0	12.4	0.1	1	27.75	93.5	6.5678	60.3696
2025	11	13	11	10	0	12.4	0.1	1	28.58	94.2	6.5739	62.1732
2025	11	13	11	20	0	12.4	0.1	1	28.72	95.2	6.5678	62.331
2025	11	13	11	30	0	12.4	0.1	1	28.51	95	6.5678	61.8951
2025	11	13	11	40	0	14.2	0.1	1	27.95	93.3	6.5678	60.8053
2025	11	13	11	50	0	13.4	0.1	1	28.31	95.1	6.5678	61.4591
2025	11	13	12	0	0	12.8	0.1	1	28.83	95.4	6.5556	62.4278
2025	11	13	12	10	0	13.4	0.1	1	27.85	96	6.5617	60.311
2025	11	13	12	20	0	12.8	0.1	1	28.8	94.8	6.5678	62.5487
2025	11	13	12	30	0	12.6	0.1	1	28.26	96.1	6.5556	61.1226
2025	11	13	12	40	0	12.6	0.1	1	27.48	94.4	6.5556	59.5999
2025	11	13	12	50	0	13	0.1	1	27.25	93.6	6.5434	59.0502
2025	11	13	13	0	0	13	0.1	1	27.57	94	6.5434	59.7014
2025	11	13	13	10	0	13	0.1	1	28.31	95.1	6.5434	61.221
2025	11	13	13	20	0	13.2	0.1	1	27.68	94.4	6.5434	59.9184
2025	11	13	13	30	0	13.2	0.1	1	27.58	94.4	6.5434	59.7012
2025	11	13	13	40	0	13.4	0.1	1	28.1	94.9	6.5252	60.6096
2025	11	13	13	50	0	13.4	0.1	1	27.64	93.1	6.5313	59.8019
2025	11	13	14	0	0	12.4	0.1	1	27.34	92.9	6.5313	59.1518
2025	11	13	14	10	0	12.4	0.1	1	28.02	95.3	6.5191	60.3342
2025	11	13	14	20	0	12.4	0.1	1	26.98	94.5	6.5191	58.1717
2025	11	13	14	30	0	12.6	0.1	1	27.76	93.7	6.5191	59.9016
2025	11	13	14	40	0	12.8	0.1	1	27.6	95	6.513	59.4111
2025	11	13	14	50	0	12.4	0.1	1	27.33	92.7	6.513	58.979
2025	11	13	15	0	0	12.4	0.1	1	27.2	94.9	6.5069	58.4898
2025	11	13	15	10	0	13.4	0.1	1	27.7	94.8	6.5008	59.5107
2025	11	13	15	20	0	12.4	0.1	1	27.34	93.1	6.5069	58.9214
2025	11	13	15	30	0	12.4	0.1	1	27.38	94.4	6.5008	58.8638
2025	11	13	15	40	0	12.2	0.1	1	28.64	95.6	6.4947	61.3912
2025	11	13	15	50	0	12.2	0.1	1	27.57	94	6.4947	59.2371

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	13	16	0	0	12.2	0.1	1	26.42	95.4	6.4886	56.5968
2025	11	13	16	10	0	12.2	0.1	1	28.17	94.1	6.4825	60.4111
2025	11	13	16	20	0	12.2	0.1	1	28.22	95.3	6.4764	60.3518
2025	11	13	16	30	0	12.2	0.1	1	27.22	95.5	6.4764	58.2041
2025	11	13	16	40	0	12.2	0.1	1	27.81	95.2	6.4764	59.4927
2025	11	13	16	50	0	12.2	0.1	1	27.42	95.4	6.4703	58.576
2025	11	13	17	0	0	12.2	0.1	1	28.46	96.1	6.4642	60.662
2025	11	13	17	10	0	12.2	0.1	1	26.68	94.5	6.4581	56.962
2025	11	13	17	20	0	12.2	0.1	1	27.36	96.3	6.4642	58.3041
2025	11	13	17	30	0	12.2	0.1	1	27.85	93.5	6.4642	59.5902
2025	11	13	17	40	0	12.2	0.1	1	28.15	93.5	6.452	60.1149
2025	11	13	17	50	0	12	0.1	1	26.9	94.9	6.452	57.3337
2025	11	13	18	0	0	12	0.1	1	26.4	95	6.452	56.2641
2025	11	13	18	10	0	12	0.1	1	26.57	94.1	6.4459	56.6361
2025	11	13	18	20	0	12	0.1	1	27.45	93.6	6.4459	58.5595
2025	11	13	18	30	0	12	0.1	1	27.47	94.2	6.4398	58.5018
2025	11	13	18	40	0	12	0.1	1	27.45	93.3	6.452	58.6173
2025	11	13	18	50	0	12	0.1	1	26.13	95.7	6.4398	55.5126
2025	11	13	19	0	0	12	0.1	1	27.72	92.3	6.4398	59.1423
2025	11	13	19	10	0	12	0.1	1	27.36	96.3	6.4398	58.0748
2025	11	13	19	20	0	12	0.1	0.9	26.64	95.8	6.4337	56.5243
2025	11	13	19	30	0	12	0.1	0.9	26.6	95	6.4337	56.5243
2025	11	13	19	40	0	12	0.1	0.9	26.22	92.4	6.4337	55.8844
2025	11	13	19	50	0	12	0.1	0.9	27.2	94.9	6.4276	57.747
2025	11	13	20	0	0	12	0.1	0.9	26.97	94	6.4215	57.2642
2025	11	13	20	10	0	12	0.1	0.9	27.22	95.5	6.4276	57.747
2025	11	13	20	20	0	12	0.1	0.9	27.19	96.8	6.4215	57.4771
2025	11	13	20	30	0	12	0.1	0.9	26.66	93.9	6.4215	56.6256
2025	11	13	20	40	0	12	0.1	0.9	26.75	96	6.4215	56.6256
2025	11	13	20	50	0	12	0.1	0.9	26.55	93.7	6.4154	56.3569
2025	11	13	21	0	0	12	0.1	0.9	26.78	94.5	6.4093	56.7259
2025	11	13	21	10	0	12	0.1	0.9	26.66	93.9	6.4093	56.5135
2025	11	13	21	20	0	12	0.1	0.9	27.18	94.4	6.4032	57.5187
2025	11	13	21	30	0	12	0.1	0.9	26.97	94.3	6.4032	57.0942
2025	11	13	21	40	0	12	0.1	0.9	26.13	92.9	6.4032	55.3963
2025	11	13	21	50	0	12	0.1	0.9	26.45	93.7	6.4032	56.033
2025	11	13	22	0	0	12	0.1	0.9	27.03	95.5	6.3971	57.0376
2025	11	13	22	10	0	12	0.1	0.9	27.37	94.2	6.391	57.8282
2025	11	13	22	20	0	12	0.1	0.9	26.2	95	6.385	55.2313
2025	11	13	22	30	0	12	0.1	0.9	26.22	95.5	6.385	55.2313
2025	11	13	22	40	0	12	0.1	1	26.97	94.3	6.385	56.9243
2025	11	13	22	50	0	12	0.1	1	27.13	95.7	6.385	57.1359
2025	11	13	23	0	0	12	0.1	0.9	26.83	95.6	6.3789	56.4448
2025	11	13	23	10	0	12	0.1	1	27.77	96.4	6.385	58.4056
2025	11	13	23	20	0	12	0.1	1	26.33	95.7	6.3789	55.3878
2025	11	13	23	30	0	12	0.1	1	27.24	92.9	6.3789	57.5018
2025	11	13	23	40	0	12	0.1	0.9	26.48	94.3	6.3728	55.755
2025	11	13	23	50	0	12	0.1	0.9	25.97	94.2	6.3728	54.699

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	14	0	0	0	12	0.1	0.9	26.72	92.4	6.3667	56.3323
2025	11	14	0	10	0	12	0.1	0.9	26.73	95.6	6.3667	56.1214
2025	11	14	0	20	0	11.8	0.1	0.9	26.59	94.7	6.3667	55.9104
2025	11	14	0	30	0	11.8	0.1	0.9	26.23	92.8	6.3667	55.2775
2025	11	14	0	40	0	11.8	0.1	0.9	26.81	95.1	6.3667	56.3324
2025	11	14	0	50	0	11.8	0.1	0.9	26.24	93.1	6.3728	55.3327
2025	11	14	1	0	0	11.8	0.1	0.9	26.43	95.6	6.3667	55.4885
2025	11	14	1	10	0	11.8	0.1	0.9	25.59	94.9	6.3667	53.8006
2025	11	14	1	20	0	11.8	0.1	0.9	26.07	96.6	6.3606	54.59
2025	11	14	1	30	0	11.8	0.1	0.9	26.48	94.5	6.3545	55.5882
2025	11	14	1	40	0	11.8	0.1	0.9	25.73	95.8	6.3545	53.9038
2025	11	14	1	50	0	11.8	0.1	0.9	26.36	96.3	6.3545	55.1671
2025	11	14	2	0	0	11.8	0.1	0.9	26.24	93.1	6.3545	55.1672
2025	11	14	2	10	0	11.8	0.1	0.9	26.01	95.3	6.3545	54.5355
2025	11	14	2	20	0	11.8	0.1	0.9	27.39	94.6	6.3545	57.4834
2025	11	14	2	30	0	11.8	0.1	0.9	26.85	93.6	6.3606	56.487
2025	11	14	2	40	0	11.8	0.1	0.9	26.87	94.1	6.3545	56.4306
2025	11	14	2	50	0	11.8	0.1	0.9	25.38	96.8	6.3545	53.0616
2025	11	14	3	0	0	11.8	0.1	0.9	25.75	93.6	6.3545	54.1144
2025	11	14	3	10	0	11.8	0.1	0.9	26.27	94.1	6.3545	55.1672
2025	11	14	3	20	0	11.8	0.1	0.9	25.93	92.9	6.3545	54.5356
2025	11	14	3	30	0	11.8	0.1	0.9	27.11	95.1	6.3545	56.8518
2025	11	14	3	40	0	11.8	0.1	0.9	25.89	94.7	6.3484	54.2707
2025	11	14	3	50	0	11.8	0.1	0.9	25.61	95.4	6.3484	53.6396
2025	11	14	4	0	0	11.8	0.1	0.9	27.19	96.8	6.3423	56.738
2025	11	14	4	10	0	11.8	0.1	0.9	26.42	95.4	6.3484	55.3224
2025	11	14	4	20	0	11.8	0.1	0.9	26.65	93.7	6.3484	55.9535
2025	11	14	4	30	0	11.8	0.1	0.9	26.23	95.7	6.3484	54.9017
2025	11	14	4	40	0	11.8	0.1	0.9	26.36	93.9	6.3423	55.2671
2025	11	14	4	50	0	11.8	0.1	0.9	24.83	93	6.3362	52.0627
2025	11	14	5	0	0	11.8	0.1	0.9	25.94	93.3	6.3423	54.4265
2025	11	14	5	10	0	11.8	0.1	0.9	27.38	96.5	6.3423	57.1583
2025	11	14	5	20	0	11.8	0.1	0.9	25.89	94.7	6.3362	54.162
2025	11	14	5	30	0	11.8	0.1	0.9	25.98	94.4	6.3362	54.372
2025	11	14	5	40	0	11.8	0.1	0.9	26.05	96.2	6.3362	54.372
2025	11	14	5	50	0	11.8	0.1	0.9	25.64	93.4	6.3301	53.6883
2025	11	14	6	0	0	11.8	0.1	0.9	26.52	95.4	6.3362	55.4216
2025	11	14	6	10	0	11.8	0.1	0.9	25.98	94.4	6.3301	54.3174
2025	11	14	6	20	0	11.8	0.1	0.9	26.38	94.3	6.3362	55.2117
2025	11	14	6	30	0	11.8	0.1	0.9	26.42	95.4	6.3362	55.2117
2025	11	14	6	40	0	11.8	0.1	0.9	26	90.9	6.3362	54.5819
2025	11	14	6	50	0	11.8	0.1	0.9	26.54	93	6.3301	55.5758
2025	11	14	7	0	0	11.8	0.1	0.9	26.31	97.2	6.3301	54.7369
2025	11	14	7	10	0	11.8	0.1	0.9	26.68	94.3	6.3301	55.7855
2025	11	14	7	20	0	11.8	0.1	0.9	25.95	93.5	6.3301	54.3174
2025	11	14	7	30	0	11.8	0.1	0.9	25	95	6.3301	52.2202
2025	11	14	7	40	0	11.8	0.1	0.9	27.22	95.3	6.324	56.777
2025	11	14	7	50	0	11.8	0.1	0.9	26.48	94.5	6.3301	55.366

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	14	8	0	0	11.8	0.1	0.9	25.27	94.3	6.324	52.7963
2025	11	14	8	10	0	11.8	0.1	0.9	27.29	96.7	6.324	56.777
2025	11	14	8	20	0	11.8	0.1	0.9	25.24	93.2	6.324	52.7963
2025	11	14	8	30	0	11.8	0.1	0.9	26.61	91.5	6.324	55.7294
2025	11	14	8	40	0	11.8	0.1	0.9	26.43	92.6	6.324	55.3104
2025	11	14	8	50	0	11.8	0.1	0.9	26.41	95.2	6.3179	55.0455
2025	11	14	9	0	0	11.8	0.1	0.9	26.02	95.5	6.3179	54.2083
2025	11	14	9	10	0	11.8	0.1	0.9	26.34	93	6.324	55.1009
2025	11	14	9	20	0	11.8	0.1	0.9	25.26	93.9	6.3179	52.7432
2025	11	14	9	30	0	11.8	0.1	0.9	25.44	93.2	6.3179	53.1617
2025	11	14	9	40	0	11.8	0.1	0.9	25.76	93.8	6.3179	53.7896
2025	11	14	9	50	0	11.8	0.1	0.9	25.89	94.7	6.3179	53.9989
2025	11	14	10	0	0	11.8	0.1	0.9	25.27	94.3	6.3179	52.7431
2025	11	14	10	10	0	11.8	0.1	0.9	26.58	94.5	6.3179	55.464
2025	11	14	10	20	0	11.8	0.1	0.9	24.58	94.7	6.3118	51.2264
2025	11	14	10	30	0	11.8	0.1	0.9	26.12	97.5	6.3179	54.2082
2025	11	14	10	40	0	11.8	0.1	0.9	26.38	94.3	6.3118	54.99
2025	11	14	10	50	0	11.8	0.1	0.9	26.23	95.7	6.3118	54.5718
2025	11	14	11	0	0	11.8	0.1	0.9	25.63	92.9	6.3118	53.5263
2025	11	14	11	10	0	12	0.1	0.9	25.96	93.8	6.3118	54.1536
2025	11	14	11	20	0	12	0.1	0.9	26.16	96.4	6.3118	54.3627
2025	11	14	11	30	0	12.2	0.1	0.9	26.46	93.9	6.3118	55.199
2025	11	14	11	40	0	12.4	0.1	0.9	26.53	95.6	6.3118	55.199
2025	11	14	11	50	0	12.6	0.1	0.9	26.29	94.8	6.3118	54.7808
2025	11	14	12	0	0	12.6	0.1	0.9	25.88	94.4	6.3118	53.9444
2025	11	14	12	10	0	12.4	0.1	0.9	25.93	92.9	6.3118	54.1535
2025	11	14	12	20	0	12.6	0.1	0.9	25.89	94.7	6.3118	53.9444
2025	11	14	12	30	0	12.6	0.1	0.9	26.69	96.9	6.3057	55.3521
2025	11	14	12	40	0	12.6	0.1	0.9	26.93	95.5	6.3118	56.0352
2025	11	14	12	50	0	12.4	0.1	0.9	27.02	95.3	6.3118	56.2443
2025	11	14	13	0	0	12.6	0.1	0.9	25.53	92.9	6.3118	53.317
2025	11	14	13	10	0	12.6	0.1	0.9	26.59	94.7	6.3118	55.4079
2025	11	14	13	20	0	12.4	0.1	0.9	27.01	95.1	6.3057	56.1875
2025	11	14	13	30	0	12.4	0.1	0.9	25.29	94.8	6.3057	52.6366
2025	11	14	13	40	0	12.4	0.1	0.9	26.18	94.6	6.3057	54.5165
2025	11	14	13	50	0	12.4	0.1	0.9	26.93	95.5	6.3057	55.9786
2025	11	14	14	0	0	12.4	0.1	0.9	25.33	95.9	6.3118	52.6896
2025	11	14	14	10	0	12.4	0.1	0.9	25.92	95.5	6.3057	53.8898
2025	11	14	14	20	0	12.4	0.1	0.9	25.65	96.3	6.3057	53.2631
2025	11	14	14	30	0	12.4	0.1	0.9	26.1	95.1	6.3057	54.3075
2025	11	14	14	40	0	12.2	0.1	0.9	25.79	94.9	6.3118	53.735
2025	11	14	14	50	0	12.2	0.1	0.9	26.72	95.4	6.3057	55.5607
2025	11	14	15	0	0	12.2	0.1	0.9	26.98	94.5	6.3057	56.1873
2025	11	14	15	10	0	12.2	0.1	0.9	26.57	94.1	6.3118	55.4076
2025	11	14	15	20	0	12.2	0.1	0.9	26.01	95.3	6.3118	54.1531
2025	11	14	15	30	0	12	0.1	0.9	26.55	93.5	6.3057	55.3518
2025	11	14	15	40	0	12	0.1	0.9	26.06	94	6.3118	54.3622
2025	11	14	15	50	0	12	0.1	0.9	25.06	98.3	6.3118	51.8532

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	14	16	0	0	12	0.1	0.9	24.83	95.8	6.3118	51.6441
2025	11	14	16	10	0	12	0.1	0.9	25.97	96.6	6.3118	53.944
2025	11	14	16	20	0	12	0.1	0.9	25.02	95.5	6.3118	52.0622
2025	11	14	16	30	0	12	0.1	0.9	26.12	97.5	6.3118	54.1531
2025	11	14	16	40	0	12	0.1	0.9	25.37	96.6	6.3118	52.6895
2025	11	14	16	50	0	12	0.1	0.9	25.51	97.4	6.3118	52.8986
2025	11	14	17	0	0	12	0.1	0.9	25.43	97.7	6.3118	52.6895
2025	11	14	17	10	0	12	0.1	0.9	24.42	95.6	6.3118	50.8077
2025	11	14	17	20	0	12	0.1	0.9	23.81	100.6	6.3118	48.9259
2025	11	14	17	30	0	11.8	0.1	0.9	25.36	96.3	6.3118	52.6895
2025	11	14	17	40	0	11.8	0.1	0.9	24.98	96.9	6.3118	51.8531
2025	11	14	17	50	0	11.8	0.1	0.9	25.12	95.7	6.3118	52.2713
2025	11	14	18	0	0	11.8	0.1	0.9	25.79	94.7	6.3118	53.7349
2025	11	14	18	10	0	11.8	0.1	0.9	24.76	98.4	6.3118	51.2259
2025	11	14	18	20	0	11.8	0.1	0.9	24.3	99	6.3179	50.231
2025	11	14	18	30	0	11.8	0.1	0.9	25.44	97.9	6.3118	52.6895
2025	11	14	18	40	0	11.8	0.1	0.9	25.9	97.1	6.3118	53.7349
2025	11	14	18	50	0	11.8	0.1	0.9	25.42	97.5	6.3179	52.7426
2025	11	14	19	0	0	11.8	0.1	0.9	24.65	98.2	6.3179	51.0682
2025	11	14	19	10	0	11.8	0.1	0.9	25.74	96	6.3179	53.5798
2025	11	14	19	20	0	11.8	0.1	0.9	26.18	94.6	6.3179	54.6263
2025	11	14	19	30	0	11.8	0.1	0.9	25.1	97.3	6.3179	52.1147
2025	11	14	19	40	0	11.8	0.1	0.9	25.37	96.6	6.3179	52.7426
2025	11	14	19	50	0	11.8	0.1	0.9	25.6	97.2	6.3179	53.1612
2025	11	14	20	0	0	11.8	0.1	0.9	24.89	94.8	6.3179	51.9054
2025	11	14	20	10	0	11.6	0.1	0.9	24.53	93	6.3179	51.2775
2025	11	14	20	20	0	11.6	0.1	0.9	25.51	95.4	6.3179	53.1612
2025	11	14	20	30	0	11.6	0.1	0.9	24.93	93	6.3179	52.1147
2025	11	14	20	40	0	11.6	0.1	0.9	25.51	95.4	6.3179	53.1612
2025	11	14	20	50	0	11.6	0.1	0.9	25.4	95	6.3179	52.9519
2025	11	14	21	0	0	11.6	0.1	0.9	24.63	95.8	6.3179	51.2776
2025	11	14	21	10	0	11.6	0.1	0.9	24.95	93.7	6.3118	52.0623
2025	11	14	21	20	0	11.6	0.1	0.9	26.17	96.6	6.3118	54.3623
2025	11	14	21	30	0	11.6	0.1	0.9	25.97	94.2	6.3118	54.1532
2025	11	14	21	40	0	11.6	0.1	0.9	25.32	95.7	6.3118	52.6896
2025	11	14	21	50	0	11.6	0.1	0.9	25.33	95.9	6.3118	52.6896
2025	11	14	22	0	0	11.6	0.1	0.9	25.69	94.7	6.3118	53.5259
2025	11	14	22	10	0	11.6	0.1	0.9	25.92	92.4	6.3118	54.1532
2025	11	14	22	20	0	11.6	0.1	0.9	26.04	93.3	6.3118	54.3623
2025	11	14	22	30	0	11.6	0.1	0.9	26.58	94.3	6.3118	55.4077
2025	11	14	22	40	0	11.6	0.1	0.9	25.62	95.6	6.3118	53.3169
2025	11	14	22	50	0	11.6	0.1	0.9	25.69	94.7	6.3118	53.526
2025	11	14	23	0	0	11.6	0.1	0.9	26.31	91.5	6.3179	55.045
2025	11	14	23	10	0	11.6	0.1	0.9	25.63	92.9	6.3179	53.5799
2025	11	14	23	20	0	11.6	0.1	0.9	27.07	96.4	6.3179	56.3008
2025	11	14	23	30	0	11.6	0.1	0.9	26.34	93.3	6.3179	55.045
2025	11	14	23	40	0	11.6	0.1	0.9	26.57	96.5	6.3179	55.2543
2025	11	14	23	50	0	11.6	0.1	0.9	25.99	94.9	6.3179	54.2078

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	15	0	0	0	11.6	0.1	0.9	25.97	94.2	6.3179	54.2078
2025	11	15	0	10	0	11.6	0.1	0.9	26.51	95.2	6.3179	55.2543
2025	11	15	0	20	0	11.6	0.1	0.9	25.59	94.9	6.3179	53.3707
2025	11	15	0	30	0	11.6	0.1	0.9	25.68	94.5	6.3179	53.58
2025	11	15	0	40	0	11.6	0.1	0.9	25.88	94.4	6.3179	53.9986
2025	11	15	0	50	0	11.6	0.1	0.9	25.33	92.7	6.3179	52.9521
2025	11	15	1	0	0	11.6	0.1	0.9	24.46	94	6.324	51.1198
2025	11	15	1	10	0	11.6	0.1	0.9	26.01	95.3	6.324	54.2624
2025	11	15	1	20	0	11.6	0.1	0.9	26.83	92.8	6.324	56.148
2025	11	15	1	30	0	11.6	0.1	0.9	25.74	93.1	6.324	53.8434
2025	11	15	1	40	0	11.6	0.1	0.9	26.36	93.9	6.324	55.1005
2025	11	15	1	50	0	11.6	0.1	0.9	26.57	94.1	6.3301	55.5753
2025	11	15	2	0	0	11.6	0.1	0.9	27.2	94.9	6.3301	56.8336
2025	11	15	2	10	0	11.6	0.1	0.9	25.76	93.8	6.3301	53.8976
2025	11	15	2	20	0	11.6	0.1	0.9	25.25	93.6	6.3362	52.9021
2025	11	15	2	30	0	11.6	0.1	0.9	25.15	93.6	6.3423	52.745
2025	11	15	2	40	0	11.6	0.1	0.9	25.34	93.4	6.3423	53.1653
2025	11	15	2	50	0	11.6	0.1	0.9	25.53	95.8	6.3423	53.3754
2025	11	15	3	0	0	11.6	0.1	0.9	25.08	94.6	6.3423	52.5349
2025	11	15	3	10	0	11.6	0.1	0.9	26.84	93	6.3423	56.3174
2025	11	15	3	20	0	11.6	0.1	0.9	26.18	94.6	6.3423	54.8464
2025	11	15	3	30	0	11.6	0.1	0.9	25.53	92.7	6.3484	53.6393
2025	11	15	3	40	0	11.6	0.1	0.9	27.15	93.6	6.3484	57.0049
2025	11	15	3	50	0	11.6	0.1	0.9	26.04	93.1	6.3484	54.691
2025	11	15	4	0	0	11.6	0.1	0.9	25.16	93.9	6.3484	52.7979
2025	11	15	4	10	0	11.6	0.1	0.9	26.75	96	6.3484	55.9531
2025	11	15	4	20	0	11.6	0.1	0.9	25.64	96	6.3484	53.6393
2025	11	15	4	30	0	11.6	0.1	0.9	25.75	96.2	6.3484	53.8496
2025	11	15	4	40	0	11.6	0.1	0.9	24.97	94.4	6.3484	52.3772
2025	11	15	4	50	0	11.6	0.1	0.9	26.55	93.7	6.3545	55.7986
2025	11	15	5	0	0	11.6	0.1	0.9	25.59	94.9	6.3484	53.6393
2025	11	15	5	10	0	11.6	0.1	0.9	24.82	95.5	6.3545	52.0085
2025	11	15	5	20	0	11.6	0.1	0.9	26.98	94.5	6.3545	56.6409
2025	11	15	5	30	0	11.6	0.1	0.9	25.63	92.7	6.3545	53.9036
2025	11	15	5	40	0	11.6	0.1	0.9	25.68	94.5	6.3545	53.9036
2025	11	15	5	50	0	11.6	0.1	0.9	25.92	95.5	6.3545	54.3247
2025	11	15	6	0	0	11.6	0.1	0.9	25.31	95.4	6.3545	53.0613
2025	11	15	6	10	0	11.6	0.1	0.9	25.89	94.7	6.3606	54.379
2025	11	15	6	20	0	11.6	0.1	0.9	26.53	95.6	6.3606	55.6437
2025	11	15	6	30	0	11.6	0.1	0.9	26.11	95.3	6.3606	54.8006
2025	11	15	6	40	0	11.6	0.1	0.9	25.73	95.8	6.3606	53.9575
2025	11	15	6	50	0	11.6	0.1	0.9	26.18	94.6	6.3606	55.0113
2025	11	15	7	0	0	11.6	0.1	0.9	25.81	95.3	6.3606	54.1682
2025	11	15	7	10	0	11.6	0.1	0.9	26.45	93.7	6.3606	55.6436
2025	11	15	7	20	0	11.2	0.1	0.9	26.83	92.8	6.3667	56.5432
2025	11	15	7	30	0	11	0.1	0.9	25.24	93.2	6.3667	53.1675
2025	11	15	7	40	0	11	0.1	0.9	27.27	94	6.3667	57.3871
2025	11	15	7	50	0	11	0.1	0.9	25.25	93.6	6.3667	53.1674

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	15	8	0	0	11.2	0.1	0.9	25.36	93.8	6.3667	53.3784
2025	11	15	8	10	0	11.2	0.1	0.9	25.64	93.1	6.3667	54.0114
2025	11	15	8	20	0	11.2	0.1	0.9	26.33	95.7	6.3667	55.2772
2025	11	15	8	30	0	11.2	0.1	0.9	25.74	93.1	6.3667	54.2223
2025	11	15	8	40	0	11.2	0.1	0.9	24.73	93	6.3728	52.1646
2025	11	15	8	50	0	11.2	0.1	0.9	26.64	93.2	6.3728	56.1772
2025	11	15	9	0	0	11.2	0.1	0.9	25.4	95.2	6.3728	53.4317
2025	11	15	9	10	0	11.4	0.1	0.9	25.06	93.9	6.3728	52.7981
2025	11	15	9	20	0	11.4	0.1	0.9	26.38	94.3	6.3728	55.5436
2025	11	15	9	30	0	11.4	0.1	0.9	26.96	93.8	6.3728	56.8107
2025	11	15	9	40	0	11.4	0.1	0.9	25.86	94	6.3728	54.4876
2025	11	15	9	50	0	11.4	0.1	0.9	26.13	92.9	6.3728	55.1212
2025	11	15	10	0	0	11.4	0.1	0.9	25.03	93	6.3789	52.8507
2025	11	15	10	10	0	11.4	0.1	0.9	26.59	94.7	6.3789	56.0218
2025	11	15	10	20	0	11.4	0.1	0.9	26.48	94.5	6.3789	55.8104
2025	11	15	10	30	0	11.4	0.1	0.9	25.36	93.8	6.3789	53.4849
2025	11	15	10	40	0	11.4	0.1	0.9	26.55	93.7	6.3789	56.0217
2025	11	15	10	50	0	11.4	0.1	0.9	26.1	90.7	6.3789	55.1761
2025	11	15	11	0	0	11.6	0.1	0.9	26.13	92.9	6.385	55.2311
2025	11	15	11	10	0	11.6	0.1	0.9	26.92	91.9	6.385	56.924
2025	11	15	11	20	0	11.4	0.1	0.9	27.24	95.9	6.385	57.3472
2025	11	15	11	30	0	11.4	0.1	0.9	25.67	94.2	6.385	54.173
2025	11	15	11	40	0	11.4	0.1	0.9	26.93	92.8	6.385	56.924
2025	11	15	11	50	0	11.4	0.1	0.9	25.88	94.4	6.385	54.5962
2025	11	15	12	0	0	11.4	0.1	0.9	26.3	97	6.385	55.231
2025	11	15	12	10	0	11.4	0.1	0.9	26.33	92.8	6.391	55.7097
2025	11	15	12	20	0	11.4	0.1	0.9	27.38	94.4	6.391	57.8279
2025	11	15	12	30	0	11.4	0.1	0.9	25.86	93.8	6.391	54.6505
2025	11	15	12	40	0	11.6	0.1	0.9	26.98	94.5	6.391	56.9806
2025	11	15	12	50	0	11.4	0.1	0.9	25.89	94.7	6.391	54.6505
2025	11	15	13	0	0	11.4	0.1	0.9	26.87	96.4	6.391	56.5569
2025	11	15	13	10	0	11.4	0.1	0.9	25.85	93.5	6.391	54.6505
2025	11	15	13	20	0	11.4	0.1	0.9	26.01	95.3	6.3971	54.9169
2025	11	15	13	30	0	11.4	0.1	0.9	26.16	93.9	6.3971	55.341
2025	11	15	13	40	0	11.2	0.1	0.9	26.99	94.7	6.3971	57.0372
2025	11	15	13	50	0	11.4	0.1	0.9	26.08	94.6	6.4032	55.1837
2025	11	15	14	0	0	11.4	0.1	0.9	27.5	95	6.4032	58.1551
2025	11	15	14	10	0	11.4	0.1	0.9	26.58	94.3	6.4093	56.3008
2025	11	15	14	20	0	11.4	0.1	0.9	26.28	94.6	6.4032	55.6082
2025	11	15	14	30	0	11.2	0.1	0.9	25	95	6.4154	52.9539
2025	11	15	14	40	0	11.2	0.1	0.9	25.99	94.9	6.4154	55.0806
2025	11	15	14	50	0	11.2	0.1	0.9	26.86	93.8	6.4154	56.9946
2025	11	15	15	0	0	11.2	0.1	0.9	27.22	95.3	6.4154	57.6326
2025	11	15	15	10	0	11.2	0.1	0.9	25.78	94.4	6.4154	54.6553
2025	11	15	15	20	0	11.2	0.1	0.9	25.73	92.9	6.4215	54.7094
2025	11	15	15	30	0	11.2	0.1	0.9	27.06	93.8	6.4276	57.5337
2025	11	15	15	40	0	11.2	0.1	0.9	26.26	93.7	6.4276	55.829
2025	11	15	15	50	0	11.2	0.1	0.9	27.96	96.2	6.4276	59.2384

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	15	16	0	0	11.2	0.1	0.9	25.69	94.9	6.4337	54.6044
2025	11	15	16	10	0	11.2	0.1	1	25.83	92.9	6.4398	55.0854
2025	11	15	16	20	0	11	0.1	1	26.45	93.7	6.4398	56.3665
2025	11	15	16	30	0	11	0.1	1	26.47	94.1	6.4398	56.3665
2025	11	15	16	40	0	11	0.1	1	26.45	93.5	6.4398	56.3665
2025	11	15	16	50	0	11	0.1	1	25.83	92.9	6.4459	55.1398
2025	11	15	17	0	0	11	0.1	1	26.23	92.6	6.4459	55.9947
2025	11	15	17	10	0	11	0.1	1	27.29	94.6	6.4459	58.1319
2025	11	15	17	20	0	11	0.1	1	26.65	93.7	6.4459	56.8496
2025	11	15	17	30	0	11	0.1	1	26.17	96.6	6.4459	55.5673
2025	11	15	17	40	0	11	0.1	1	26.49	94.8	6.4459	56.4222
2025	11	15	17	50	0	11	0.1	1	27.49	94.6	6.4459	58.5594
2025	11	15	18	0	0	11	0.1	1	26.16	93.9	6.452	55.836
2025	11	15	18	10	0	11	0.1	1	26.74	93	6.452	57.1196
2025	11	15	18	20	0	11.6	0.1	1	26.86	93.8	6.4581	57.39
2025	11	15	18	30	0	11.6	0.1	1	26.93	92.8	6.4581	57.6042
2025	11	15	18	40	0	11.6	0.1	1	27.17	94.2	6.4581	58.0325
2025	11	15	18	50	0	11.6	0.1	1	26.85	93.6	6.4581	57.39
2025	11	15	19	0	0	11.6	0.1	1	26.22	95.5	6.4581	55.8911
2025	11	15	19	10	0	11.6	0.1	1	26.87	94.3	6.4581	57.3901
2025	11	15	19	20	0	11.6	0.1	1	25.89	94.7	6.4581	55.2486
2025	11	15	19	30	0	11.6	0.1	1	27.67	94.1	6.4581	59.1032
2025	11	15	19	40	0	11.6	0.1	1	27.05	93.4	6.4581	57.8184
2025	11	15	19	50	0	11.6	0.1	1	26.45	93.7	6.4581	56.5335
2025	11	15	20	0	0	11.6	0.1	1	26.22	92.4	6.4581	56.1052
2025	11	15	20	10	0	11.6	0.1	1	26.81	95.1	6.4581	57.176
2025	11	15	20	20	0	11.6	0.1	1	25.89	94.7	6.4642	55.3031
2025	11	15	20	30	0	11.6	0.1	1	26.45	93.5	6.4642	56.5892
2025	11	15	20	40	0	11.6	0.1	1	25.79	94.7	6.4642	55.0887
2025	11	15	20	50	0	11.6	0.1	1	27.1	91.1	6.4642	58.0897
2025	11	15	21	0	0	11.6	0.1	1	26.85	93.6	6.4642	57.4466
2025	11	15	21	10	0	11.6	0.1	1	27.55	93.5	6.4642	58.9471
2025	11	15	21	20	0	11.6	0.1	1	27.7	94.8	6.4581	59.1033
2025	11	15	21	30	0	11.6	0.1	1	26.13	92.9	6.4581	55.8912
2025	11	15	21	40	0	11.6	0.1	1	26.72	95.4	6.4581	56.9619
2025	11	15	21	50	0	11.6	0.1	1	27.27	94	6.4581	58.2468
2025	11	15	22	0	0	11.6	0.1	1	27.07	94	6.4581	57.8185
2025	11	15	22	10	0	11.6	0.1	1	27.05	93.4	6.4581	57.8185
2025	11	15	22	20	0	11.6	0.1	1	27.07	96.4	6.4642	57.6611
2025	11	15	22	30	0	11.6	0.1	1	27.32	95.5	6.4642	58.3041
2025	11	15	22	40	0	11.6	0.1	1	26.63	92.8	6.4703	57.0741
2025	11	15	22	50	0	11.6	0.1	1	26.22	92	6.4703	56.2158
2025	11	15	23	0	0	11.6	0.1	1	26.86	96.2	6.4703	57.2887
2025	11	15	23	10	0	11.6	0.1	1	27.13	92.5	6.4703	58.1469
2025	11	15	23	20	0	11.6	0.1	1	25.89	94.7	6.4703	55.3576
2025	11	15	23	30	0	11.6	0.1	1	26.95	93.6	6.4703	57.7178
2025	11	15	23	40	0	11.6	0.1	1	28.22	95.3	6.4642	60.2334
2025	11	15	23	50	0	11.6	0.1	1	26.42	92	6.4581	56.5337

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	16	0	0	0	11.6	0.1	1	26.55	93.7	6.4581	56.7479
2025	11	16	0	10	0	11.6	0.1	1	27.07	96.4	6.4581	57.6045
2025	11	16	0	20	0	11.6	0.1	1	27.41	95	6.4642	58.5186
2025	11	16	0	30	0	11.6	0.1	1	27.39	94.6	6.4642	58.5186
2025	11	16	0	40	0	11.6	0.1	1	27.4	94.8	6.4581	58.4611
2025	11	16	0	50	0	11.6	0.1	1	27.41	95	6.4581	58.4611
2025	11	16	1	0	0	11.6	0.1	1	26	95.1	6.4581	55.4631
2025	11	16	1	10	0	11.6	0.1	1	26.88	94.5	6.452	57.3339
2025	11	16	1	20	0	11.6	0.1	1	27.89	94.5	6.4581	59.5318
2025	11	16	1	30	0	11.6	0.1	1	27.47	94.2	6.4581	58.6753
2025	11	16	1	40	0	11.6	0.1	1	27.66	93.7	6.452	59.0454
2025	11	16	1	50	0	11.6	0.1	1	25.79	94.7	6.452	54.9807
2025	11	16	2	0	0	11.6	0.1	1	27.78	94.3	6.452	59.2594
2025	11	16	2	10	0	11.6	0.1	1	27.07	94	6.452	57.7619
2025	11	16	2	20	0	11.6	0.1	1	27.63	92.5	6.452	59.0455
2025	11	16	2	30	0	11.6	0.1	1	26.66	93.9	6.452	56.9061
2025	11	16	2	40	0	11.6	0.1	1	28.19	94.7	6.4459	60.0559
2025	11	16	2	50	0	11.6	0.1	1	27.68	94.4	6.4459	58.9873
2025	11	16	3	0	0	11.6	0.1	1	26.91	95.1	6.4459	57.2776
2025	11	16	3	10	0	11.6	0.1	1	27.46	93.8	6.4459	58.5599
2025	11	16	3	20	0	11.6	0.1	1	25.69	94.9	6.4459	54.7129
2025	11	16	3	30	0	11.6	0.1	1	27.17	96.3	6.4459	57.705
2025	11	16	3	40	0	11.6	0.1	1	27.31	95	6.4459	58.1325
2025	11	16	3	50	0	11.6	0.1	1	27.14	93.2	6.4398	57.8617
2025	11	16	4	0	0	11.6	0.1	1	27.13	95.7	6.4398	57.6481
2025	11	16	4	10	0	11.6	0.1	1	26.9	94.9	6.4398	57.2211
2025	11	16	4	20	0	11.6	0.1	1	27.18	94.4	6.4398	57.8617
2025	11	16	4	30	0	11.6	0.1	1	26.2	95	6.4398	55.7266
2025	11	16	4	40	0	11.6	0.1	1	27.25	93.6	6.4398	58.0752
2025	11	16	4	50	0	11.6	0.1	1	26.46	93.9	6.4398	56.3671
2025	11	16	5	0	0	11.6	0.1	1	26.43	95.6	6.4398	56.1536
2025	11	16	5	10	0	11.6	0.1	1	25.91	95.3	6.4398	55.0861
2025	11	16	5	20	0	11.6	0.1	1	26.42	95.4	6.4337	56.0982
2025	11	16	5	30	0	11.6	0.1	1	26.09	94.8	6.4398	55.5131
2025	11	16	5	40	0	11.6	0.1	1	26.34	95.9	6.4398	55.9401
2025	11	16	5	50	0	11.6	0.1	1	27.27	94	6.4337	58.0179
2025	11	16	6	0	0	11.6	0.1	1	26.28	94.6	6.4337	55.8849
2025	11	16	6	10	0	11.6	0.1	1	26.64	93.2	6.4337	56.7382
2025	11	16	6	20	0	11.6	0.1	1	27.15	93.6	6.4337	57.8047
2025	11	16	6	30	0	11.6	0.1	1	26.38	94.3	6.4337	56.0983
2025	11	16	6	40	0	11.6	0.1	1	26.73	95.6	6.4337	56.7382
2025	11	16	6	50	0	11.6	0.1	1	27.05	93.6	6.4337	57.5914
2025	11	16	7	0	0	11.6	0.1	1	27.03	92.8	6.4337	57.5914
2025	11	16	7	10	0	11.6	0.1	1	26.55	93.7	6.4337	56.5249
2025	11	16	7	20	0	11.6	0.1	1	27.47	94.2	6.4337	58.4446
2025	11	16	7	30	0	11.6	0.1	1	26.46	93.9	6.4337	56.3116
2025	11	16	7	40	0	11.6	0.1	1	26.89	94.7	6.4337	57.1648
2025	11	16	7	50	0	11.6	0.1	1	26.68	94.5	6.4337	56.7383

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	16	8	0	0	11.6	0.1	1	26.09	94.8	6.4337	55.4585
2025	11	16	8	10	0	11.6	0.1	1	26.92	95.3	6.4337	57.1649
2025	11	16	8	20	0	11.6	0.1	1	27.11	95.1	6.4337	57.5915
2025	11	16	8	30	0	11.6	0.1	1	26.28	94.6	6.4337	55.8851
2025	11	16	8	40	0	11.6	0.1	1	27.87	96.4	6.4337	59.0846
2025	11	16	8	50	0	11.6	0.1	1	27.3	96.9	6.4337	57.8048
2025	11	16	9	0	0	11.6	0.1	1	26.32	95.5	6.4337	55.8851
2025	11	16	9	10	0	11.6	0.1	1	26.96	96.2	6.4398	57.2214
2025	11	16	9	20	0	11.6	0.1	1	25.68	94.5	6.4337	54.6053
2025	11	16	9	30	0	11.6	0.1	1	26.35	96.1	6.4337	55.8852
2025	11	16	9	40	0	11.6	0.1	1	26.58	94.5	6.4337	56.5251
2025	11	16	9	50	0	11.6	0.1	1	26.69	94.7	6.4337	56.7384
2025	11	16	10	0	0	11.6	0.1	1	26.89	94.7	6.4337	57.165
2025	11	16	10	10	0	11.6	0.1	1	27.78	96.6	6.4337	58.8714
2025	11	16	10	20	0	11.6	0.1	1	26.24	95.9	6.4398	55.7269
2025	11	16	10	30	0	11.8	0.1	1	26.71	95.2	6.4398	56.7945
2025	11	16	10	40	0	11.8	0.1	1	26.83	95.6	6.4398	57.008
2025	11	16	10	50	0	11.8	0.1	1	25.5	95.2	6.4398	54.2323
2025	11	16	11	0	0	11.8	0.1	1	25.68	94.5	6.4398	54.6593
2025	11	16	11	10	0	11.8	0.1	1	26.76	93.9	6.4398	57.008
2025	11	16	11	20	0	12	0.1	1	27.03	95.5	6.4398	57.435
2025	11	16	11	30	0	12	0.1	1	26.65	93.7	6.4398	56.7945
2025	11	16	11	40	0	12	0.1	1	26.44	95.9	6.4398	56.1539
2025	11	16	11	50	0	12.2	0.1	1	26.35	96.1	6.4398	55.9404
2025	11	16	12	0	0	12.2	0.1	1	26.41	95.2	6.4398	56.1539
2025	11	16	12	10	0	12.4	0.1	1	26.83	95.6	6.4398	57.0079
2025	11	16	12	20	0	12.4	0.1	1	26.67	94.1	6.4459	56.8505
2025	11	16	12	30	0	12.2	0.1	1	26.59	98.4	6.4459	56.2093
2025	11	16	12	40	0	12.2	0.1	1	25.92	95.5	6.4459	55.1407
2025	11	16	12	50	0	12.2	0.1	1	25.85	96.2	6.452	54.9811
2025	11	16	13	0	0	12.2	0.1	1	26.12	95.5	6.452	55.6229
2025	11	16	13	10	0	12.2	0.1	1	26.77	96.4	6.452	56.9065
2025	11	16	13	20	0	12.2	0.1	1	26.37	96.5	6.4581	56.106
2025	11	16	13	30	0	12.6	0.1	1	26.79	94.7	6.452	57.1204
2025	11	16	13	40	0	12.2	0.1	1	27.21	97.2	6.452	57.7622
2025	11	16	13	50	0	12.2	0.1	1	26.31	95.2	6.4581	56.1059
2025	11	16	14	0	0	12.4	0.1	1	27.27	94.2	6.452	58.19
2025	11	16	14	10	0	12.4	0.1	1	26.81	95.1	6.4581	57.1766
2025	11	16	14	20	0	12.4	0.1	1	26.61	95.2	6.4642	56.8042
2025	11	16	14	30	0	12.4	0.1	1	27.57	94.2	6.4642	58.9477
2025	11	16	14	40	0	12.2	0.1	1	25.89	94.9	6.4703	55.358
2025	11	16	14	50	0	12.2	0.1	1	26.55	96.1	6.4703	56.6454
2025	11	16	15	0	0	12.4	0.1	1	27.25	96.1	6.4703	58.1474
2025	11	16	15	10	0	12.4	0.1	1	27.17	94	6.4703	58.1474
2025	11	16	15	20	0	12.4	0.1	1	26.22	95.5	6.4764	56.0567
2025	11	16	15	30	0	12.4	0.1	1	26.72	95.4	6.4764	57.1306
2025	11	16	15	40	0	12.4	0.1	1	27.73	95.6	6.4764	59.2783
2025	11	16	15	50	0	12.4	0.1	1	26.32	97.4	6.4825	56.1117

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	16	16	0	0	12.2	0.1	1	26.97	94.3	6.4825	57.8316
2025	11	16	16	10	0	12.2	0.1	1	26.66	96.2	6.4825	56.9716
2025	11	16	16	20	0	12.2	0.1	1	26.22	95.5	6.4825	56.1117
2025	11	16	16	30	0	12.2	0.1	1	26.77	94.3	6.4886	57.4578
2025	11	16	16	40	0	12.2	0.1	1	27.7	94.8	6.4947	59.4528
2025	11	16	16	50	0	12	0.1	1	27.29	94.6	6.4947	58.5912
2025	11	16	17	0	0	12	0.1	1	28.1	94.9	6.4947	60.3144
2025	11	16	17	10	0	12	0.1	1	26.73	92.8	6.4947	57.5141
2025	11	16	17	20	0	12	0.1	1	27.08	94.4	6.5008	58.2172
2025	11	16	17	30	0	12	0.1	1	27.17	94.2	6.5008	58.4329
2025	11	16	17	40	0	12	0.1	1	26.76	93.9	6.5008	57.5704
2025	11	16	17	50	0	12	0.1	1	26.36	93.9	6.5008	56.7079
2025	11	16	18	0	0	11.8	0.1	1	27.48	94.4	6.5008	59.0797
2025	11	16	18	10	0	11.8	0.1	1	27.05	93.6	6.5069	58.2742
2025	11	16	18	20	0	11.8	0.1	1	28.26	93.7	6.5008	60.8047
2025	11	16	18	30	0	11.8	0.1	1	26.58	94.5	6.5069	57.1951
2025	11	16	18	40	0	11.8	0.1	1	26.61	95.2	6.5069	57.1951
2025	11	16	18	50	0	11.8	0.1	1	27.32	92.3	6.5069	58.9217
2025	11	16	19	0	0	11.8	0.1	1	26.62	92.2	6.5069	57.4109
2025	11	16	19	10	0	11.8	0.1	1	27.67	93.9	6.5069	59.5692
2025	11	16	19	20	0	11.8	0.1	1	27.55	93.5	6.513	59.4114
2025	11	16	19	30	0	11.8	0.1	1	28.01	95.1	6.513	60.2756
2025	11	16	19	40	0	11.8	0.1	1	26.55	93.5	6.513	57.251
2025	11	16	19	50	0	11.8	0.1	1	27.74	93.1	6.513	59.8435
2025	11	16	20	0	0	11.8	0.1	1	27.88	94.3	6.513	60.0596
2025	11	16	20	10	0	11.8	0.1	1	26.72	91.9	6.513	57.6832
2025	11	16	20	20	0	11.8	0.1	1	27.98	94.3	6.5191	60.3345
2025	11	16	20	30	0	11.8	0.1	1	28.78	94.2	6.5191	62.0645
2025	11	16	20	40	0	11.8	0.1	1	27.52	92.3	6.5191	59.4695
2025	11	16	20	50	0	11.6	0.1	1	27.91	95.1	6.5191	60.1183
2025	11	16	21	0	0	11.6	0.1	1	27.01	97.2	6.5191	57.9558
2025	11	16	21	10	0	11.6	0.1	1	28.41	95	6.5313	61.3189
2025	11	16	21	20	0	11.6	0.1	1	28.29	94.7	6.5313	61.1023
2025	11	16	21	30	0	11.6	0.1	1	27.43	92.7	6.5374	59.4267
2025	11	16	21	40	0	11.6	0.1	1	27.76	93.7	6.5374	60.0773
2025	11	16	21	50	0	11.6	0.1	1	27.85	93.5	6.5434	60.3529
2025	11	16	22	0	0	11.6	0.1	1	27.42	92.3	6.5434	59.4845
2025	11	16	22	10	0	11.6	0.1	1	26.65	93.7	6.5434	57.7477
2025	11	16	22	20	0	11.6	0.1	1	27.31	91.7	6.5434	59.2674
2025	11	16	22	30	0	11.6	0.1	1	28.2	94.9	6.5495	61.0635
2025	11	16	22	40	0	11.6	0.1	1	27.73	92.7	6.5495	60.1943
2025	11	16	22	50	0	11.6	0.1	1	28.63	92.8	6.5495	62.1501
2025	11	16	23	0	0	11.6	0.1	1	27.33	92.7	6.5495	59.3251
2025	11	16	23	10	0	11.6	0.1	1	27.48	94.4	6.5495	59.5424
2025	11	16	23	20	0	11.6	0.1	1	28.45	95.9	6.5495	61.4982
2025	11	16	23	30	0	11.6	0.1	1	28.25	93.4	6.5495	61.2809
2025	11	16	23	40	0	11.6	0.1	1	28.03	92.7	6.5495	60.8463
2025	11	16	23	50	0	11.6	0.1	1	28.16	93.9	6.5495	61.0637

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	17	0	0	0	11.6	0.1	1	27.44	92.9	6.5495	59.5425
2025	11	17	0	10	0	11.6	0.1	1	27.66	93.7	6.5495	59.9772
2025	11	17	0	20	0	11.6	0.1	1	27.61	95.2	6.5495	59.7599
2025	11	17	0	30	0	11.6	0.1	1	27.28	94.4	6.5495	59.108
2025	11	17	0	40	0	11.6	0.1	1	28.54	93	6.5495	61.9331
2025	11	17	0	50	0	11.6	0.1	1	27.57	94.2	6.5495	59.76
2025	11	17	1	0	0	11.6	0.1	1	28.52	92.2	6.5495	61.9331
2025	11	17	1	10	0	11.6	0.1	1	27.58	94.4	6.5495	59.7601
2025	11	17	1	20	0	11.6	0.1	1	27.74	92.9	6.5495	60.1947
2025	11	17	1	30	0	11.6	0.1	1	27.49	94.6	6.5495	59.5428
2025	11	17	1	40	0	11.6	0.1	1	27.05	93.6	6.5495	58.6736
2025	11	17	1	50	0	11.6	0.1	1	27.66	93.7	6.5495	59.9775
2025	11	17	2	0	0	11.6	0.1	1	27.88	94.3	6.5495	60.4121
2025	11	17	2	10	0	11.6	0.1	1	27.88	94.3	6.5495	60.4122
2025	11	17	2	20	0	11.6	0.1	1	28.18	94.3	6.5495	61.0641
2025	11	17	2	30	0	11.6	0.1	1	27.14	93	6.5495	58.891
2025	11	17	2	40	0	11.6	0.1	1	26.26	93.7	6.5495	56.9353
2025	11	17	2	50	0	11.6	0.1	1	27.47	94	6.5495	59.543
2025	11	17	3	0	0	11.6	0.1	1	27.18	94.4	6.5495	58.8911
2025	11	17	3	10	0	11.6	0.1	1	27.47	94.2	6.5495	59.5431
2025	11	17	3	20	0	11.6	0.1	1	27.94	92.9	6.5495	60.6296
2025	11	17	3	30	0	11.6	0.1	1	26.77	94.1	6.5495	58.022
2025	11	17	3	40	0	11.6	0.1	1	26.53	92.6	6.5495	57.5874
2025	11	17	3	50	0	11.4	0.1	1	26.83	92.8	6.5434	58.1828
2025	11	17	4	0	0	11.4	0.1	1	26.95	93.4	6.5434	58.3999
2025	11	17	4	10	0	11.4	0.1	1	27.15	93.6	6.5434	58.8342
2025	11	17	4	20	0	11.4	0.1	1	26.68	94.5	6.5434	57.7487
2025	11	17	4	30	0	11.4	0.1	1	27.81	91.9	6.5434	60.3539
2025	11	17	4	40	0	11.4	0.1	1	28.25	93.4	6.5434	61.2224
2025	11	17	4	50	0	11.4	0.1	1	27.38	94.4	6.5434	59.2685
2025	11	17	5	0	0	11.4	0.1	1	27.46	93.8	6.5434	59.4856
2025	11	17	5	10	0	11.4	0.1	1	27.13	92.7	6.5374	58.7772
2025	11	17	5	20	0	11.4	0.1	1	27.43	95.6	6.5374	59.211
2025	11	17	5	30	0	11.4	0.1	1	27.3	91	6.5374	59.211
2025	11	17	5	40	0	11.4	0.1	1	26.91	91.7	6.5374	58.3435
2025	11	17	5	50	0	11.4	0.1	1	27.08	94.4	6.5374	58.5604
2025	11	17	6	0	0	11.4	0.1	1	26.6	90.9	6.5313	57.6368
2025	11	17	6	10	0	11.4	0.1	1	26.55	93.7	6.5313	57.4201
2025	11	17	6	20	0	11.4	0.1	1	26.83	92.8	6.5313	58.0702
2025	11	17	6	30	0	11.4	0.1	1	27.35	93.4	6.5313	59.1536
2025	11	17	6	40	0	11.4	0.1	1	27.05	93.4	6.5313	58.5036
2025	11	17	6	50	0	11.4	0.1	1	26.84	93.2	6.5313	58.0703
2025	11	17	7	0	0	11.4	0.1	1	26.52	95.4	6.5252	57.1479
2025	11	17	7	10	0	11.4	0.1	1	26.98	94.5	6.5252	58.2303
2025	11	17	7	20	0	11.4	0.1	1	26.85	93.4	6.5252	58.0138
2025	11	17	7	30	0	11.4	0.1	1	27.03	92.5	6.5191	58.3899
2025	11	17	7	40	0	11.4	0.1	1	27.22	92.3	6.5191	58.8224
2025	11	17	7	50	0	11.4	0.1	1	26.34	93.3	6.5191	56.8761

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	17	8	0	0	11.4	0.1	1	26.81	95.1	6.5191	57.7411
2025	11	17	8	10	0	11.4	0.1	1	27.23	92.5	6.513	58.7651
2025	11	17	8	20	0	11.6	0.1	1	26.42	95.4	6.5069	56.7653
2025	11	17	8	30	0	11.8	0.1	1	26.73	92.6	6.5069	57.6286
2025	11	17	8	40	0	12	0.1	1	27.24	93.2	6.5008	58.6505
2025	11	17	8	50	0	12	0.1	1	27.27	94.2	6.4947	58.5932
2025	11	17	9	0	0	12.4	0.1	1	26.8	91.1	6.4886	57.675
2025	11	17	9	10	0	12.6	0.1	1	26.44	93.3	6.4886	56.8142
2025	11	17	9	20	0	12.2	0.1	1	27.71	91.7	6.4825	59.5535
2025	11	17	9	30	0	12.2	0.1	1	27.1	91.1	6.4825	58.2635
2025	11	17	9	40	0	12.6	0.1	1	26.11	91.5	6.4825	56.1136
2025	11	17	9	50	0	12.6	0.1	1	26.81	95.1	6.4825	57.4035
2025	11	17	10	0	0	12.2	0.1	1	26.64	93.2	6.4764	57.1324
2025	11	17	10	10	0	12.2	0.1	1	26.51	91.7	6.4764	56.9176
2025	11	17	10	20	0	12.4	0.1	1	26.9	94.9	6.4764	57.562
2025	11	17	10	30	0	12.4	0.1	1	27.46	93.8	6.4764	58.8507
2025	11	17	10	40	0	12.4	0.1	1	27.24	93.2	6.4764	58.4211
2025	11	17	10	50	0	12.2	0.1	1	26.74	93.2	6.4703	57.2909
2025	11	17	11	0	0	12.2	0.1	1	27.11	95.1	6.4703	57.9346
2025	11	17	11	10	0	12.2	0.1	1	28.05	93.5	6.4703	60.0803
2025	11	17	11	20	0	12.2	0.1	1	27.89	94.5	6.4703	59.6511
2025	11	17	11	30	0	12.2	0.1	1	26.52	95.4	6.4703	56.6471
2025	11	17	11	40	0	12.2	0.1	1	26.12	95.5	6.4703	55.7888
2025	11	17	11	50	0	12.2	0.1	1	26.68	94.3	6.4703	57.0762
2025	11	17	12	0	0	12.2	0.1	1	26.7	94.9	6.4703	57.0762
2025	11	17	12	10	0	12.2	0.1	1	26.73	95.6	6.4703	57.0762
2025	11	17	12	20	0	12.2	0.1	1	27.7	94.8	6.4642	59.1637
2025	11	17	12	30	0	12	0.1	1	28.01	91.2	6.4642	60.0211
2025	11	17	12	40	0	12	0.1	1	27.46	93.8	6.4581	58.6772
2025	11	17	12	50	0	12	0.1	1	26.28	94.6	6.4642	56.1626
2025	11	17	13	0	0	12	0.1	1	26.27	94.1	6.4581	56.1074
2025	11	17	13	10	0	12	0.1	1	26.84	93	6.452	57.3358
2025	11	17	13	20	0	12	0.1	1	26.58	94.5	6.452	56.694
2025	11	17	13	30	0	12	0.1	1	26.09	94.8	6.452	55.6243
2025	11	17	13	40	0	12	0.1	1	26.43	92.6	6.452	56.48
2025	11	17	13	50	0	12	0.1	1	26.34	95.9	6.4459	55.9969
2025	11	17	14	0	0	11.8	0.1	1	26.97	96.4	6.4398	57.2228
2025	11	17	14	10	0	12	0.1	1	26.75	96	6.4459	56.8518
2025	11	17	14	20	0	12	0.1	1	26.65	93.7	6.4398	56.7957
2025	11	17	14	30	0	12	0.1	1	25.97	94.2	6.4398	55.3011
2025	11	17	14	40	0	12	0.1	1	26.6	95	6.4337	56.5263
2025	11	17	14	50	0	11.8	0.1	1	26.62	92.2	6.4337	56.7397
2025	11	17	15	0	0	11.8	0.1	1	25.86	94	6.4337	55.0332
2025	11	17	15	10	0	11.8	0.1	1	27.13	92.7	6.4337	57.8062
2025	11	17	15	20	0	11.8	0.1	1	26.96	93.8	6.4398	57.4362
2025	11	17	15	30	0	11.8	0.1	1	25.72	95.6	6.4276	54.5526
2025	11	17	15	40	0	11.8	0.1	1	25.84	93.3	6.4215	54.9244
2025	11	17	15	50	0	11.8	0.1	1	26.63	95.6	6.4215	56.4146

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	17	16	0	0	11.8	0.1	1	26.57	96.5	6.4276	56.2574
2025	11	17	16	10	0	11.8	0.1	1	26.62	95.4	6.4215	56.4146
2025	11	17	16	20	0	11.8	0.1	1	26.08	94.4	6.4215	55.3502
2025	11	17	16	30	0	11.8	0.1	1	26.93	95.5	6.4154	56.9968
2025	11	17	16	40	0	11.8	0.1	1	26.1	95.1	6.4215	55.3502
2025	11	17	16	50	0	11.8	0.1	1	26.2	95	6.4154	55.508
2025	11	17	17	0	0	11.6	0.1	1	27.65	93.5	6.4154	58.6982
2025	11	17	17	10	0	11.6	0.1	1	26.47	94.1	6.4154	56.1461
2025	11	17	17	20	0	11.6	0.1	1	26.06	94	6.4154	55.2953
2025	11	17	17	30	0	11.6	0.1	1	26.01	95.3	6.4154	55.0827
2025	11	17	17	40	0	11.6	0.1	1	26.18	94.4	6.4154	55.508
2025	11	17	17	50	0	11.6	0.1	1	25.78	96.7	6.4093	54.3907
2025	11	17	18	0	0	11.6	0.1	1	26.1	95.1	6.4093	55.2406
2025	11	17	18	10	0	11.6	0.1	1	25.62	95.6	6.4093	54.1783
2025	11	17	18	20	0	11.6	0.1	1	25.56	94	6.4093	54.1783
2025	11	17	18	30	0	11.6	0.1	1	26.49	94.8	6.4032	56.0348
2025	11	17	18	40	0	11.6	0.1	1	25.71	91.8	6.4032	54.549
2025	11	17	18	50	0	11.6	0.1	1	25.47	94.3	6.4032	53.9123
2025	11	17	19	0	0	11.6	0.1	1	25.56	93.8	6.4032	54.1245
2025	11	17	19	10	0	11.6	0.1	1	25.54	93.4	6.4032	54.1246
2025	11	17	19	20	0	11.6	0.1	1	25.88	94.4	6.4032	54.7613
2025	11	17	19	30	0	11.6	0.1	1	26.22	92	6.4032	55.6103
2025	11	17	19	40	0	11.6	0.1	1	26.95	93.6	6.4032	57.0961
2025	11	17	19	50	0	11.6	0.1	1	25.15	93.6	6.4032	53.2756
2025	11	17	20	0	0	11.6	0.1	1	26.43	95.6	6.3971	55.7672
2025	11	17	20	10	0	11.6	0.1	1	25.22	95.7	6.3971	53.2227
2025	11	17	20	20	0	11.6	0.1	1	25.74	96	6.391	54.229
2025	11	17	20	30	0	11.6	0.1	1	26.62	95.4	6.3971	56.1913
2025	11	17	20	40	0	11.6	0.1	1	25.69	94.7	6.3971	54.2829
2025	11	17	20	50	0	11.6	0.1	1	26.08	94.4	6.391	55.0763
2025	11	17	21	0	0	11.6	0.1	1	25.93	95.8	6.391	54.6526
2025	11	17	21	10	0	11.6	0.1	1	26.65	96	6.391	56.1355
2025	11	17	21	20	0	11.6	0.1	1	25.56	94	6.385	53.9634
2025	11	17	21	30	0	11.6	0.1	1	26.97	94.3	6.3789	56.8694
2025	11	17	21	40	0	11.6	0.1	1	25.75	93.6	6.3789	54.3325
2025	11	17	21	50	0	11.6	0.1	1	26.52	92.2	6.3789	56.0238
2025	11	17	22	0	0	11.6	0.1	1	26.07	94.2	6.385	55.0216
2025	11	17	22	10	0	11.6	0.1	1	26.95	93.6	6.391	56.9828
2025	11	17	22	20	0	11.6	0.1	1	25.89	94.7	6.391	54.6527
2025	11	17	22	30	0	11.6	0.1	1	26.81	95.1	6.385	56.5029
2025	11	17	22	40	0	11.6	0.1	1	25.48	96.8	6.391	53.5935
2025	11	17	22	50	0	11.6	0.1	1	25.59	94.7	6.391	54.0172
2025	11	17	23	0	0	11.6	0.1	1	26.96	93.8	6.385	56.9262
2025	11	17	23	10	0	11.6	0.1	1	26.08	94.4	6.385	55.0216
2025	11	17	23	20	0	11.6	0.1	1	25.95	93.5	6.3789	54.7554
2025	11	17	23	30	0	11.6	0.1	1	26.55	93.7	6.385	56.0797
2025	11	17	23	40	0	11.6	0.1	1	26.92	95.3	6.385	56.7146
2025	11	17	23	50	0	11.6	0.1	1	25.52	95.6	6.391	53.8054

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	18	0	0	0	11.6	0.1	1	26.63	95.6	6.391	56.1356
2025	11	18	0	10	0	11.6	0.1	1	25.06	94.1	6.391	52.9581
2025	11	18	0	20	0	11.6	0.1	1	25.15	93.6	6.391	53.17
2025	11	18	0	30	0	11.6	0.1	1	25.71	91.3	6.385	54.3868
2025	11	18	0	40	0	11.6	0.1	1	25.86	93.8	6.385	54.5984
2025	11	18	0	50	0	11.6	0.1	1	25.96	93.8	6.385	54.8101
2025	11	18	1	0	0	11.6	0.1	1	25.45	93.6	6.385	53.7519
2025	11	18	1	10	0	11.6	0.1	1	25.86	93.8	6.385	54.5985
2025	11	18	1	20	0	11.6	0.1	1	25.43	92.7	6.385	53.752
2025	11	18	1	30	0	11.4	0.1	1	25.62	92.2	6.3789	54.1213
2025	11	18	1	40	0	11.4	0.1	1	25.46	93.8	6.3789	53.6985
2025	11	18	1	50	0	11.4	0.1	1	24.21	91.9	6.3789	51.1616
2025	11	18	2	0	0	11.4	0.1	1	24.35	93.8	6.3789	51.373
2025	11	18	2	10	0	11.4	0.1	1	25.88	94.4	6.3789	54.5442
2025	11	18	2	20	0	11.4	0.1	0.9	25.01	91.8	6.3728	52.8002
2025	11	18	2	30	0	11.4	0.1	0.9	25.3	90.9	6.3728	53.4339
2025	11	18	2	40	0	11.4	0.1	0.9	24.65	93.7	6.3728	51.9555
2025	11	18	2	50	0	11.4	0.1	0.9	24.75	93.7	6.3728	52.1667
2025	11	18	3	0	0	11.4	0.1	0.9	26.85	96	6.3728	56.3907
2025	11	18	3	10	0	11.4	0.1	0.9	26.47	94.1	6.3728	55.7572
2025	11	18	3	20	0	11.4	0.1	0.9	26.66	93.9	6.3667	56.1235
2025	11	18	3	30	0	11.4	0.1	0.9	25.79	94.7	6.3667	54.2246
2025	11	18	3	40	0	11.4	0.1	0.9	25.26	93.9	6.3667	53.1697
2025	11	18	3	50	0	11.4	0.1	0.9	26.44	93.3	6.3667	55.7016
2025	11	18	4	0	0	11.4	0.1	0.9	24.53	92.8	6.3606	51.6412
2025	11	18	4	10	0	11.4	0.1	0.9	25.06	94.1	6.3545	52.6424
2025	11	18	4	20	0	11.4	0.1	0.9	25.87	94.2	6.3545	54.327
2025	11	18	4	30	0	11.4	0.1	0.9	24.88	94.6	6.3545	52.2213
2025	11	18	4	40	0	11.4	0.1	0.9	26.05	93.5	6.3545	54.7481
2025	11	18	4	50	0	11.4	0.1	0.9	26.08	94.6	6.3484	54.6934
2025	11	18	5	0	0	11.4	0.1	0.9	24.53	92.8	6.3484	51.538
2025	11	18	5	10	0	11.4	0.1	0.9	25.05	93.7	6.3484	52.5898
2025	11	18	5	20	0	11.4	0.1	0.9	26.26	93.7	6.3484	55.1141
2025	11	18	5	30	0	11.4	0.1	0.9	25.36	94.1	6.3484	53.2209
2025	11	18	5	40	0	11.4	0.1	0.9	25.8	90.7	6.3423	54.2184
2025	11	18	5	50	0	11.4	0.1	0.9	25.46	94.1	6.3484	53.4313
2025	11	18	6	0	0	11.4	0.1	0.9	25.98	94.4	6.3423	54.4285
2025	11	18	6	10	0	11.4	0.1	0.9	26.04	93.1	6.3423	54.6387
2025	11	18	6	20	0	11.4	0.1	0.9	25.82	92.2	6.3423	54.2184
2025	11	18	6	30	0	11.4	0.1	0.9	25.59	94.9	6.3423	53.588
2025	11	18	6	40	0	11.4	0.1	0.9	25.78	94.4	6.3423	54.0083
2025	11	18	6	50	0	11.4	0.1	0.9	24.53	93	6.3423	51.4865
2025	11	18	7	0	0	11.4	0.1	0.9	25.81	91.6	6.3423	54.2184
2025	11	18	7	10	0	11.4	0.1	0.9	25.43	92.9	6.3423	53.3778
2025	11	18	7	20	0	11.4	0.1	0.9	26.35	96.1	6.3423	55.0591
2025	11	18	7	30	0	11.4	0.1	0.9	26.11	97.3	6.3423	54.4286
2025	11	18	7	40	0	11.4	0.1	0.9	25.46	94.1	6.3423	53.3779
2025	11	18	7	50	0	11.4	0.1	0.9	25.68	94.5	6.3423	53.7982

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	18	8	0	0	11.4	0.1	0.9	25.84	96	6.3423	54.0084
2025	11	18	8	10	0	11.4	0.1	0.9	24.96	94.1	6.3423	52.3272
2025	11	18	8	20	0	11.4	0.1	0.9	24.82	95.5	6.3423	51.9069
2025	11	18	8	30	0	11.4	0.1	0.9	24.55	96.3	6.3423	51.2764
2025	11	18	8	40	0	11.4	0.1	0.9	25.56	93.8	6.3362	53.5344
2025	11	18	8	50	0	11.6	0.1	0.9	24.52	95.6	6.3362	51.225
2025	11	18	9	0	0	11.6	0.1	0.9	25.34	93.4	6.3362	53.1145
2025	11	18	9	10	0	11.6	0.1	0.9	25.31	95.4	6.3362	52.9046
2025	11	18	9	20	0	11.6	0.1	0.9	25.27	94.3	6.3423	52.9577
2025	11	18	9	30	0	11.6	0.1	0.9	25.26	93.9	6.3362	52.9046
2025	11	18	9	40	0	11.6	0.1	0.9	24.63	92.8	6.3423	51.6968
2025	11	18	9	50	0	11.6	0.1	0.9	25.11	95.5	6.3423	52.5374
2025	11	18	10	0	0	11.6	0.1	0.9	24.99	94.8	6.3423	52.3272
2025	11	18	10	10	0	11.6	0.1	0.9	26.42	95.4	6.3423	55.2693
2025	11	18	10	20	0	11.6	0.1	0.9	25.83	95.8	6.3423	54.0084
2025	11	18	10	30	0	11.8	0.1	0.9	25.33	92.9	6.3423	53.1678
2025	11	18	10	40	0	11.8	0.1	0.9	24.37	94.2	6.3423	51.0663
2025	11	18	10	50	0	11.8	0.1	0.9	25.54	93.1	6.3423	53.5881
2025	11	18	11	0	0	11.8	0.1	0.9	24.96	94.1	6.3423	52.3272
2025	11	18	11	10	0	11.8	0.1	0.9	24.85	93.7	6.3423	52.117
2025	11	18	11	20	0	11.8	0.1	0.9	25.48	94.5	6.3423	53.3779
2025	11	18	11	30	0	11.8	0.1	0.9	24.69	94.9	6.3423	51.6967
2025	11	18	11	40	0	11.8	0.1	0.9	25.86	94	6.3423	54.2185
2025	11	18	11	50	0	11.6	0.1	0.9	24.93	92.8	6.3423	52.3272
2025	11	18	12	0	0	11.8	0.1	0.9	26.2	95	6.3423	54.849
2025	11	18	12	10	0	12	0.1	0.9	24.38	94.7	6.3423	51.0663
2025	11	18	12	20	0	12	0.1	0.9	24.65	93.5	6.3423	51.6967
2025	11	18	12	30	0	12	0.1	0.9	27.12	95.3	6.3423	56.7403
2025	11	18	12	40	0	12.6	0.1	0.9	24.37	94.2	6.3423	51.0662
2025	11	18	12	50	0	12.4	0.1	0.9	24.99	94.8	6.3423	52.3271
2025	11	18	13	0	0	12.2	0.1	0.9	25.64	96	6.3423	53.588
2025	11	18	13	10	0	12.2	0.1	0.9	25.62	95.6	6.3423	53.5879
2025	11	18	13	20	0	12	0.1	0.9	24.5	95.2	6.3423	51.2763
2025	11	18	13	30	0	12	0.1	0.9	25.08	94.6	6.3423	52.5372
2025	11	18	13	40	0	12	0.1	0.9	25.26	93.9	6.3423	52.9575
2025	11	18	13	50	0	12	0.1	0.9	25.89	94.9	6.3423	54.2184
2025	11	18	14	1	10	12	0.1	0.9	24.35	93.5	6.3423	51.0661
2025	11	18	14	11	10	11.8	0.1	0.9	25.98	94.4	6.3423	54.4285
2025	11	18	14	21	10	11.8	0.1	0.9	26.65	93.4	6.3423	55.8996
2025	11	18	14	31	10	11.8	0.1	0.9	25.81	95.3	6.3423	54.0082
2025	11	18	14	41	10	11.8	0.1	0.9	26.21	91.7	6.3423	55.0589
2025	11	18	14	51	10	11.8	0.1	0.9	25.06	94.1	6.3484	52.5898
2025	11	18	15	1	10	11.8	0.1	0.9	25.84	93.3	6.3484	54.2727
2025	11	18	15	11	10	11.8	0.1	0.9	27.03	92.5	6.3545	56.8539
2025	11	18	15	21	10	11.8	0.1	0.9	25.57	94.3	6.3606	53.7491
2025	11	18	15	31	10	11.8	0.1	0.9	25.15	93.6	6.3667	52.9588
2025	11	18	15	41	10	11.8	0.1	0.9	25.4	90.9	6.3667	53.5918
2025	11	18	15	51	10	11.8	0.1	0.9	26.28	94.6	6.3667	55.2797

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	18	16	1	10	11.8	0.1	0.9	26.04	93.1	6.3728	54.9125
2025	11	18	16	11	10	11.8	0.1	0.9	25.02	92.5	6.3667	52.7478
2025	11	18	16	21	10	11.8	0.1	0.9	25.68	94.5	6.3728	54.0677
2025	11	18	16	31	10	11.8	0.1	0.9	25.72	92	6.3728	54.2789
2025	11	18	16	41	10	11.8	0.1	0.9	26.52	91.9	6.3728	55.9685
2025	11	18	16	51	10	11.6	0.1	0.9	25.82	92.2	6.3728	54.4901
2025	11	18	17	1	10	11.6	0.1	1	26.28	94.6	6.3789	55.3901
2025	11	18	17	11	10	11.6	0.1	1	25.52	92	6.3789	53.9103
2025	11	18	17	21	10	11.6	0.1	1	25.82	92	6.3789	54.5445
2025	11	18	17	31	10	11.6	0.1	1	25.68	94.5	6.3789	54.1217
2025	11	18	17	41	10	11.6	0.1	1	25.04	93.2	6.3789	52.8532
2025	11	18	17	51	10	11.6	0.1	1	26.53	92.6	6.3789	56.0244
2025	11	18	18	1	10	11.6	0.1	1	25.61	97.4	6.385	53.7524
2025	11	18	18	11	10	11.6	0.1	1	26.02	92.4	6.385	55.0221
2025	11	18	18	21	10	11.6	0.1	1	26.12	92.2	6.385	55.2337
2025	11	18	18	31	10	11.6	0.1	1	26.32	95.5	6.385	55.4454
2025	11	18	18	41	10	11.6	0.1	1	26.32	95.5	6.385	55.4454
2025	11	18	18	51	10	11.4	0.1	1	26.24	93.1	6.385	55.4454
2025	11	18	19	1	10	11.4	0.1	1	25.38	94.5	6.385	53.5408
2025	11	18	19	11	10	11.4	0.1	1	26.54	93	6.385	56.0803
2025	11	18	19	21	10	11.4	0.1	1	25.75	93.6	6.391	54.4415
2025	11	18	19	31	10	11.4	0.1	1	25.96	94	6.391	54.8652
2025	11	18	19	41	10	11.4	0.1	1	25.83	92.7	6.391	54.6533
2025	11	18	19	51	10	11.4	0.1	1	25.82	92.2	6.391	54.6534
2025	11	18	20	1	10	11.4	0.1	1	26.35	93.5	6.391	55.7125
2025	11	18	20	11	10	11.4	0.1	1	25.95	93.5	6.391	54.8652
2025	11	18	20	21	10	11.4	0.1	1	26.87	94.1	6.391	56.7717
2025	11	18	20	31	10	11.4	0.1	1	25.05	93.7	6.391	52.9587
2025	11	18	20	41	10	11.4	0.1	1	25.8	90.2	6.391	54.6534
2025	11	18	20	51	10	11.4	0.1	1	26.26	93.7	6.3971	55.556
2025	11	18	21	1	10	11.4	0.1	1	26.65	93.7	6.3971	56.4042
2025	11	18	21	11	10	11.4	0.1	1	26.15	93.5	6.3971	55.3439
2025	11	18	21	21	10	11.4	0.1	1	26.27	94.1	6.3971	55.556
2025	11	18	21	31	10	11.4	0.1	1	25.75	93.6	6.3971	54.4958
2025	11	18	21	41	10	11.4	0.1	1	26.54	93	6.4032	56.248
2025	11	18	21	51	10	11.4	0.1	1	26.16	96.4	6.4032	55.1867
2025	11	18	22	1	10	11.4	0.1	1	27.17	94	6.4032	57.5216
2025	11	18	22	11	10	11.4	0.1	1	25.5	95.2	6.4032	53.9132
2025	11	18	22	21	10	11.4	0.1	1	25.98	94.4	6.4093	55.0291
2025	11	18	22	31	10	11.4	0.1	1	24.99	94.8	6.4154	52.9569
2025	11	18	22	41	10	11.4	0.1	1	26.56	93.9	6.4276	56.4714
2025	11	18	22	51	10	11.4	0.1	1	26.37	94.1	6.4337	56.1007
2025	11	18	23	1	10	11.4	0.1	1	27.12	92.3	6.4337	57.8072
2025	11	18	23	11	10	11.4	0.1	1	26.46	93.9	6.4398	56.3696
2025	11	18	23	21	10	11.4	0.1	1	26.53	92.6	6.4398	56.5832
2025	11	18	23	31	10	11.4	0.1	1	26.91	95.1	6.4398	57.2237
2025	11	18	23	41	10	11.4	0.1	1	25.94	93.3	6.4459	55.3566
2025	11	18	23	51	10	11.4	0.1	1	26.55	93.5	6.4459	56.639

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	19	0	1	10	11.4	0.1	1	26.38	94.3	6.452	56.267
2025	11	19	0	11	10	11.4	0.1	1	26.65	93.7	6.452	56.9088
2025	11	19	0	21	10	11.4	0.1	1	26.95	93.6	6.452	57.5507
2025	11	19	0	31	10	11.4	0.1	1	26.85	93.4	6.452	57.3368
2025	11	19	0	41	10	11.4	0.1	1	26.38	94.3	6.452	56.2671
2025	11	19	0	51	10	11.4	0.1	1	25.49	94.7	6.452	54.3416
2025	11	19	1	1	10	11.4	0.1	1	27.17	94	6.4581	58.0357
2025	11	19	1	11	10	11.4	0.1	1	25.75	93.6	6.4581	55.0376
2025	11	19	1	21	10	11.4	0.1	1	26.51	95.2	6.4581	56.5367
2025	11	19	1	31	10	11.4	0.1	1	26.28	94.4	6.4581	56.1084
2025	11	19	1	41	10	11.4	0.1	1	26.74	93.2	6.4642	57.2354
2025	11	19	1	51	10	11.4	0.1	1	27.26	93.8	6.4642	58.3073
2025	11	19	2	1	10	11.4	0.1	1	26.85	93.6	6.4642	57.4498
2025	11	19	2	11	10	11.4	0.1	1	27.04	95.7	6.4642	57.6642
2025	11	19	2	21	10	11.4	0.1	1	27.53	92.5	6.4703	59.0084
2025	11	19	2	31	10	11.4	0.1	1	26.94	95.8	6.4703	57.5063
2025	11	19	2	41	10	11.4	0.1	1	26.65	93.4	6.4703	57.0772
2025	11	19	2	51	10	11.4	0.1	1	26.38	94.3	6.4764	56.4889
2025	11	19	3	1	10	11.4	0.1	1	27.55	93.3	6.4825	59.1243
2025	11	19	3	11	10	11.4	0.1	1	27.26	93.8	6.4886	58.5367
2025	11	19	3	21	10	11.4	0.1	1	26.17	94.2	6.4947	56.2244
2025	11	19	3	31	10	11.4	0.1	1	26.34	93	6.5008	56.7107
2025	11	19	3	41	10	11.4	0.1	1	27.8	95	6.5008	59.7295
2025	11	19	3	51	10	11.4	0.1	1	27.29	94.6	6.5008	58.6514
2025	11	19	4	1	10	11.4	0.1	1	26.68	94.3	6.5069	57.4137
2025	11	19	4	11	10	11.4	0.1	1	26.56	93.9	6.5069	57.1978
2025	11	19	4	21	10	11.4	0.1	1	27.62	95.4	6.5069	59.3563
2025	11	19	4	31	10	11.4	0.1	1	26.91	95.1	6.513	57.9019
2025	11	19	4	41	10	11.4	0.1	1	27.28	94.4	6.513	58.7661
2025	11	19	4	51	10	11.4	0.1	1	26.74	93	6.513	57.6858
2025	11	19	5	1	10	11.4	0.1	1	27.37	94.2	6.513	58.9822
2025	11	19	5	11	10	11.4	0.1	1	27.31	95	6.513	58.7661
2025	11	19	5	21	10	11.4	0.1	1	26.54	93.2	6.5191	57.3096
2025	11	19	5	31	10	11.4	0.1	1	28.14	93.1	6.5191	60.7698
2025	11	19	5	41	10	11.4	0.1	1	27.33	92.5	6.5191	59.0397
2025	11	19	5	51	10	11.4	0.1	1	27.6	95	6.5191	59.4723
2025	11	19	6	1	10	11.4	0.1	1	27.47	94	6.5191	59.256
2025	11	19	6	11	10	11.4	0.1	1	28	94.9	6.5191	60.3373
2025	11	19	6	21	10	11.4	0.1	1	28.05	93.5	6.5191	60.5536
2025	11	19	6	31	10	11.4	0.1	1	27.42	92.3	6.5191	59.256
2025	11	19	6	41	10	11.4	0.1	1	25.71	91.8	6.5191	55.5796
2025	11	19	6	51	10	11.4	0.1	1	26.75	93.4	6.5191	57.7422
2025	11	19	7	1	10	11.4	0.1	1	27.3	90.4	6.5252	59.0973
2025	11	19	7	11	10	11.4	0.1	1	26.71	91.7	6.5191	57.7422
2025	11	19	7	21	10	11.4	0.1	1	27.96	93.7	6.5191	60.3374
2025	11	19	7	31	10	11.4	0.1	1	27.94	93.1	6.5191	60.3374
2025	11	19	7	41	10	11.4	0.1	1	27.11	91.7	6.5191	58.6073
2025	11	19	7	51	10	11.4	0.1	1	27.2	94.9	6.5191	58.6073

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	19	8	1	10	11.4	0.1	1	28.5	90.8	6.5191	61.635
2025	11	19	8	11	10	11.4	0.1	1	26.32	92.4	6.5191	56.8772
2025	11	19	8	21	10	11.4	0.1	1	27.74	92.9	6.5191	59.9049
2025	11	19	8	31	10	11.6	0.1	1	27.93	92.5	6.5191	60.3374
2025	11	19	8	41	10	11.6	0.1	1	27.2	90.6	6.5191	58.8236
2025	11	19	8	51	10	11.6	0.1	1	28.07	94.1	6.5191	60.5537
2025	11	19	9	1	10	12	0.1	1	27.92	92.3	6.5191	60.3374
2025	11	19	9	11	10	11.8	0.1	1	26.8	90	6.5191	57.9586
2025	11	19	9	21	10	12	0.1	1	27.65	93.3	6.5191	59.6887
2025	11	19	9	31	10	12	0.1	1	26.12	92.4	6.5191	56.4447
2025	11	19	9	41	10	12	0.1	1	26.51	95.2	6.5191	57.0935
2025	11	19	9	51	10	12	0.1	1	28.54	93.2	6.5191	61.635
2025	11	19	10	1	10	12.4	0.1	1	26.42	92	6.5191	57.0935
2025	11	19	10	11	10	12.2	0.1	1	25.92	92	6.5191	56.0122
2025	11	19	10	21	10	12.2	0.1	1	25.6	90	6.513	55.3094
2025	11	19	10	31	10	12.2	0.1	1	26.31	91.7	6.513	56.8218
2025	11	19	10	41	10	12.4	0.1	1	26.2	91.1	6.513	56.6057
2025	11	19	10	51	10	12.4	0.1	1	27.11	91.5	6.513	58.5501
2025	11	19	11	1	10	12.2	0.1	1	26.32	92	6.513	56.8217
2025	11	19	11	11	10	12.2	0.1	1	27.65	93.3	6.513	59.6304
2025	11	19	11	21	10	12.2	0.1	1	26.4	89.8	6.513	57.0377
2025	11	19	11	31	10	12.4	0.1	1	26.75	93.4	6.5069	57.6296
2025	11	19	11	41	10	12.6	0.1	1	26.95	93.4	6.5069	58.0612
2025	11	19	11	51	10	12.6	0.1	1	26.5	89.1	6.5069	57.1978
2025	11	19	12	1	10	12.8	0.1	1	26.23	92.6	6.5069	56.5503
2025	11	19	12	11	10	12.4	0.1	1	27.33	92.5	6.5008	58.867
2025	11	19	12	21	10	12.8	0.1	1	26.6	90.2	6.5008	57.3575
2025	11	19	12	31	10	12.4	0.1	1	26.42	92.2	6.4947	56.8706
2025	11	19	12	41	10	12.6	0.1	1	27	90	6.4886	58.1062
2025	11	19	12	51	10	12.6	0.1	1	25.8	90	6.4825	55.4693
2025	11	19	13	1	10	12.8	0.1	1	27.35	93.4	6.4764	58.6367
2025	11	19	13	11	10	12.4	0.1	1	26.13	92.6	6.4764	56.0592
2025	11	19	13	21	10	12.6	0.1	1	26.73	92.8	6.4703	57.2916
2025	11	19	13	31	10	12.6	0.1	1	27.03	92.8	6.4703	57.9353
2025	11	19	13	41	10	12.8	0.1	1	26.9	90.9	6.4703	57.7207
2025	11	19	13	51	10	12.6	0.1	1	26.11	91.8	6.4642	55.9491
2025	11	19	14	1	10	12.8	0.1	1	25.6	90.9	6.4642	54.8773
2025	11	19	14	11	10	12.6	0.1	1	26.62	91.9	6.4642	57.0208
2025	11	19	14	21	10	12.8	0.1	1	26.63	92.6	6.4642	57.0208
2025	11	19	14	31	10	12.6	0.1	1	27.63	92.5	6.4642	59.1644
2025	11	19	14	41	10	12.8	0.1	1	26.2	90.7	6.4642	56.1632
2025	11	19	14	51	10	12.8	0.1	1	26.4	91.1	6.4642	56.5919
2025	11	19	15	1	10	12.4	0.1	1	26.52	92.4	6.4642	56.8062
2025	11	19	15	11	10	12.6	0.1	1	26.01	91.3	6.4581	55.6796
2025	11	19	15	21	10	12.8	0.1	1	26.42	92.2	6.4581	56.5362
2025	11	19	15	31	10	12.8	0.1	1	27.57	94	6.4581	58.8918
2025	11	19	15	41	10	12.8	0.1	1	26.33	92.6	6.4581	56.3219
2025	11	19	15	51	10	12.8	0.1	1	27.14	93.2	6.4581	58.0351

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	19	16	1	10	12.8	0.1	1	26.71	91.7	6.4581	57.1785
2025	11	19	16	11	10	12.8	0.1	1	26.72	92.4	6.452	57.1222
2025	11	19	16	21	10	12.2	0.1	1	26.59	94.7	6.452	56.6942
2025	11	19	16	31	10	12.2	0.1	1	26.85	93.6	6.452	57.336
2025	11	19	16	41	10	12.2	0.1	1	25.41	91.8	6.4459	54.2873
2025	11	19	16	51	10	12	0.1	1	26.43	92.6	6.4459	56.4246
2025	11	19	17	1	10	11.4	0.1	1	27.04	93	6.4337	57.5931
2025	11	19	17	11	10	11.4	0.1	1	26.63	92.8	6.4276	56.6838
2025	11	19	17	21	10	12	0.1	1	26.45	93.7	6.4276	56.2576
2025	11	19	17	31	10	12	0.1	1	27.32	92.1	6.4215	58.1179
2025	11	19	17	41	10	12	0.1	1	26.84	93	6.4215	57.0535
2025	11	19	17	51	10	12	0.1	1	26.55	93.5	6.4154	56.359
2025	11	19	18	1	10	12	0.1	1	27.33	92.5	6.4154	58.0604
2025	11	19	18	11	10	12	0.1	1	26.64	93.2	6.4154	56.5717
2025	11	19	18	21	10	12	0.1	1	26.55	93.5	6.4093	56.3031
2025	11	19	18	31	10	12	0.1	1	26.04	93.1	6.4093	55.2408
2025	11	19	18	41	10	12	0.1	1	25.32	95.7	6.4093	53.5411
2025	11	19	18	51	10	11.8	0.1	1	27.45	93.6	6.4093	58.2153
2025	11	19	19	1	10	11.8	0.1	1	25.84	93.3	6.4093	54.8159
2025	11	19	19	11	10	11.8	0.1	1	26.83	92.8	6.4032	56.8841
2025	11	19	19	21	10	11.8	0.1	1	26.81	91.3	6.4032	56.8841
2025	11	19	19	31	10	11.8	0.1	1	27.08	94.4	6.4032	57.3086
2025	11	19	19	41	10	11.8	0.1	1	25.86	93.8	6.4032	54.7616
2025	11	19	19	51	10	11.8	0.1	1	26.12	92.2	6.4032	55.3984
2025	11	19	20	1	10	11.8	0.1	1	26.23	92.6	6.4032	55.6107
2025	11	19	20	11	10	11.8	0.1	1	25.77	94.2	6.4032	54.5494
2025	11	19	20	21	10	11.8	0.1	1	26.06	93.7	6.3971	55.1314
2025	11	19	20	31	10	11.8	0.1	1	26.41	91.3	6.3971	55.9796
2025	11	19	20	41	10	11.8	0.1	1	26.23	95.7	6.3971	55.3435
2025	11	19	20	51	10	11.8	0.1	1	26.52	92.4	6.3971	56.1917
2025	11	19	21	1	10	11.8	0.1	1	26.55	93.5	6.3971	56.1918
2025	11	19	21	11	10	11.8	0.1	1	26.55	93.5	6.3971	56.1918
2025	11	19	21	21	10	11.8	0.1	1	25.55	93.6	6.391	54.0177
2025	11	19	21	31	10	11.8	0.1	1	26.55	93.5	6.391	56.1361
2025	11	19	21	41	10	11.8	0.1	1	26.25	93.5	6.391	55.5006
2025	11	19	21	51	10	11.8	0.1	1	25.22	95.7	6.391	53.1705
2025	11	19	22	1	10	11.8	0.1	1	27.07	94.2	6.391	57.1954
2025	11	19	22	11	10	11.8	0.1	1	26.82	92.4	6.391	56.7717
2025	11	19	22	21	10	11.8	0.1	1	26.26	93.9	6.385	55.4456
2025	11	19	22	31	10	11.8	0.1	1	25.75	93.6	6.385	54.3875
2025	11	19	22	41	10	11.8	0.1	1	25.91	91.5	6.385	54.8107
2025	11	19	22	51	10	11.8	0.1	1	25.73	92.9	6.385	54.3875
2025	11	19	23	1	10	11.8	0.1	1	26.81	95.1	6.3789	56.4475
2025	11	19	23	11	10	11.8	0.1	1	26.06	93.7	6.3789	54.9677
2025	11	19	23	21	10	11.8	0.1	1	25.76	94	6.3789	54.3335
2025	11	19	23	31	10	11.8	0.1	1	25.91	95.3	6.3789	54.5449
2025	11	19	23	41	10	11.8	0.1	1	25.75	93.6	6.3789	54.3335
2025	11	19	23	51	10	11.8	0.1	1	26.55	93.5	6.3789	56.0248

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	20	0	1	10	11.8	0.1	0.9	24.96	98.3	6.3728	52.1673
2025	11	20	0	11	10	11.8	0.1	0.9	26.35	93.5	6.3728	55.5466
2025	11	20	0	21	10	11.8	0.1	0.9	26.15	93.5	6.3728	55.1242
2025	11	20	0	31	10	11.8	0.1	0.9	25.96	96.4	6.3728	54.4906
2025	11	20	0	41	10	11.8	0.1	0.9	27.4	94.8	6.3728	57.6587
2025	11	20	0	51	10	11.8	0.1	0.9	25.26	94.1	6.3667	53.1703
2025	11	20	1	1	10	11.8	0.1	0.9	25.84	93.1	6.3667	54.4363
2025	11	20	1	11	10	11.8	0.1	0.9	24.83	92.8	6.3667	52.3264
2025	11	20	1	21	10	11.8	0.1	0.9	24.96	94.1	6.3667	52.5374
2025	11	20	1	31	10	11.8	0.1	0.9	26.43	92.8	6.3667	55.7023
2025	11	20	1	41	10	11.8	0.1	0.9	26.48	94.3	6.3667	55.7023
2025	11	20	1	51	10	11.8	0.1	0.9	24.93	92.8	6.3606	52.4849
2025	11	20	2	1	10	11.8	0.1	0.9	25.34	93.2	6.3606	53.3281
2025	11	20	2	11	10	11.8	0.1	0.9	25.91	91.8	6.3606	54.5928
2025	11	20	2	21	10	11.8	0.1	0.9	25.82	92	6.3545	54.3276
2025	11	20	2	31	10	11.8	0.1	0.9	25.98	94.6	6.3545	54.5382
2025	11	20	2	41	10	11.8	0.1	0.9	25.36	93.8	6.3484	53.2215
2025	11	20	2	51	10	11.8	0.1	0.9	25.25	93.6	6.3484	53.0111
2025	11	20	3	1	10	11.8	0.1	0.9	25.81	95.3	6.3423	54.0088
2025	11	20	3	11	10	11.8	0.1	0.9	25.14	93.2	6.3362	52.695
2025	11	20	3	21	10	11.6	0.1	0.9	25.19	94.8	6.3362	52.695
2025	11	20	3	31	10	11.6	0.1	0.9	24.93	93	6.3362	52.2751
2025	11	20	3	41	10	11.6	0.1	0.9	26.45	93.5	6.3301	55.3686
2025	11	20	3	51	10	11.6	0.1	0.9	24.24	93.3	6.3301	50.7546
2025	11	20	4	1	10	11.6	0.1	0.9	25.56	93.8	6.3301	53.4811
2025	11	20	4	11	10	11.6	0.1	0.9	24.12	92.4	6.3301	50.5449
2025	11	20	4	21	10	11.6	0.1	0.9	25.55	93.6	6.3301	53.4811
2025	11	20	4	31	10	11.6	0.1	0.9	26.44	93	6.3301	55.3687
2025	11	20	4	41	10	11.6	0.1	0.9	25.22	95.7	6.324	52.5893
2025	11	20	4	51	10	11.6	0.1	0.9	25.92	95.5	6.324	54.0559
2025	11	20	5	1	10	11.6	0.1	0.9	25.19	94.8	6.324	52.5893
2025	11	20	5	11	10	11.6	0.1	0.9	25.3	95.2	6.324	52.7988
2025	11	20	5	21	10	11.6	0.1	0.9	26.5	95	6.324	55.3131
2025	11	20	5	31	10	11.6	0.1	0.9	25.21	95.5	6.324	52.5893
2025	11	20	5	41	10	11.6	0.1	0.9	25.71	95.4	6.324	53.6369
2025	11	20	5	51	10	11.6	0.1	0.9	25.13	93	6.324	52.5893
2025	11	20	6	1	10	11.6	0.1	0.9	27.45	93.3	6.324	57.4083
2025	11	20	6	11	10	11.6	0.1	0.9	27.08	94.4	6.324	56.5702
2025	11	20	6	21	10	11.6	0.1	0.9	26.83	92.6	6.324	56.1512
2025	11	20	6	31	10	11.6	0.1	0.9	24.75	93.5	6.3179	51.6992
2025	11	20	6	41	10	11.6	0.1	0.9	25.59	94.7	6.3179	53.3737
2025	11	20	6	51	10	11.6	0.1	0.9	26.23	92.6	6.3179	54.8389
2025	11	20	7	1	10	11.6	0.1	0.9	25.33	95.9	6.3179	52.7458
2025	11	20	7	11	10	11.6	0.1	0.9	25.21	91.6	6.3179	52.7458
2025	11	20	7	21	10	11.6	0.1	0.9	25.74	93.3	6.3179	53.7923
2025	11	20	7	31	10	11.6	0.1	0.9	26.24	93.3	6.3179	54.8389
2025	11	20	7	41	10	11.6	0.1	0.9	24.81	91.8	6.3179	51.9086
2025	11	20	7	51	10	11.6	0.1	0.9	25.12	92.5	6.3179	52.5365

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	20	8	1	10	11.6	0.1	0.9	25.23	92.7	6.3179	52.7458
2025	11	20	8	11	10	11.6	0.1	0.9	25.26	94.1	6.3179	52.7458
2025	11	20	8	21	10	11.6	0.1	0.9	24.57	94.4	6.3179	51.2807
2025	11	20	8	31	10	11.6	0.1	0.9	26.04	93.3	6.3179	54.4203
2025	11	20	8	41	10	11.6	0.1	0.9	25.18	94.6	6.3179	52.5365
2025	11	20	8	51	10	11.6	0.1	0.9	24.62	95.6	6.3179	51.2806
2025	11	20	9	1	10	11.6	0.1	0.9	25.59	94.7	6.3179	53.3737
2025	11	20	9	11	10	11.8	0.1	0.9	25.65	93.6	6.3179	53.583
2025	11	20	9	21	10	11.8	0.1	0.9	24.98	94.6	6.3179	52.1178
2025	11	20	9	31	10	11.8	0.1	0.9	26.28	94.4	6.3179	54.8388
2025	11	20	9	41	10	11.8	0.1	0.9	25.5	95.2	6.3179	53.1643
2025	11	20	9	51	10	11.8	0.1	0.9	25.81	95.3	6.3179	53.7922
2025	11	20	10	1	10	11.8	0.1	0.9	24.73	93	6.3179	51.6991
2025	11	20	10	11	10	11.8	0.1	0.9	25.65	93.6	6.3179	53.5829
2025	11	20	10	21	10	11.8	0.1	0.9	25.63	92.7	6.3179	53.5829
2025	11	20	10	31	10	11.8	0.1	0.9	26.08	94.4	6.3179	54.4201
2025	11	20	10	41	10	11.8	0.1	0.9	25.01	91.8	6.3179	52.327
2025	11	20	10	51	10	11.8	0.1	0.9	25.76	94	6.3179	53.7921
2025	11	20	11	1	10	11.8	0.1	0.9	25.94	93.3	6.3179	54.2107
2025	11	20	11	11	10	11.8	0.1	0.9	26.96	93.8	6.3179	56.3037
2025	11	20	11	21	10	11.8	0.1	0.9	25.48	94.5	6.3179	53.1641
2025	11	20	11	31	10	11.8	0.1	0.9	24.87	94.4	6.3179	51.9082
2025	11	20	11	41	10	11.8	0.1	0.9	25.43	92.7	6.3179	53.164
2025	11	20	11	51	10	11.8	0.1	0.9	25.83	95.8	6.3179	53.7919
2025	11	20	12	1	10	11.8	0.1	0.9	26.28	94.4	6.3179	54.8385
2025	11	20	12	11	10	12	0.1	0.9	25.34	93.4	6.324	53.008
2025	11	20	12	21	10	11.8	0.1	0.9	25.78	94.4	6.324	53.846
2025	11	20	12	31	10	11.8	0.1	0.9	24.99	94.8	6.324	52.1699
2025	11	20	12	41	10	11.8	0.1	0.9	24.82	95.5	6.324	51.7508
2025	11	20	12	51	10	11.8	0.1	0.9	25.62	92.2	6.324	53.6364
2025	11	20	13	1	10	11.8	0.1	0.9	26.16	93.9	6.324	54.684
2025	11	20	13	11	10	11.8	0.1	0.9	25.71	95.4	6.324	53.6364
2025	11	20	13	21	10	11.8	0.1	0.9	25.75	93.6	6.324	53.8459
2025	11	20	13	31	10	11.8	0.1	0.9	26.34	93	6.324	55.103
2025	11	20	13	41	10	11.8	0.1	0.9	25.79	94.7	6.324	53.8459
2025	11	20	13	51	10	11.8	0.1	0.9	25.92	95.5	6.324	54.0554
2025	11	20	14	1	10	12	0.1	0.9	25.66	94	6.324	53.6363
2025	11	20	14	11	10	12	0.1	0.9	25.22	92	6.324	52.7982
2025	11	20	14	21	10	11.8	0.1	0.9	26.62	92.4	6.324	55.7315
2025	11	20	14	31	10	11.8	0.1	0.9	25.3	90.9	6.3301	53.061
2025	11	20	14	41	10	11.8	0.1	0.9	24.15	93.8	6.3301	50.5443
2025	11	20	14	51	10	11.8	0.1	0.9	25.53	92.7	6.3301	53.4805
2025	11	20	15	1	10	11.8	0.1	0.9	26.35	93.7	6.3301	55.1583
2025	11	20	15	11	10	11.8	0.1	0.9	25.52	92	6.3301	53.4805
2025	11	20	15	21	10	11.6	0.1	0.9	25.29	94.8	6.3301	52.8513
2025	11	20	15	31	10	11.6	0.1	0.9	26.38	94.6	6.3301	55.1583
2025	11	20	15	41	10	11.6	0.1	0.9	25.93	92.9	6.3301	54.3194
2025	11	20	15	51	10	11.6	0.1	0.9	25.48	94.5	6.3301	53.2707

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	20	16	1	10	11.6	0.1	0.9	25.94	93.3	6.3301	54.3194
2025	11	20	16	11	10	11.6	0.1	0.9	26.32	92.4	6.3301	55.1583
2025	11	20	16	21	10	11.6	0.1	0.9	25.31	95.4	6.3301	52.8512
2025	11	20	16	31	10	11.6	0.1	0.9	24.91	91.8	6.3362	52.2745
2025	11	20	16	41	10	11.6	0.1	0.9	25.92	92.2	6.3362	54.3739
2025	11	20	16	51	10	11.6	0.1	0.9	25.14	93.4	6.3362	52.6944
2025	11	20	17	1	10	11.6	0.1	0.9	26.04	93.1	6.3423	54.6386
2025	11	20	17	11	10	11.6	0.1	0.9	27.92	92.3	6.3423	58.6314
2025	11	20	17	21	10	11.6	0.1	0.9	26.53	92.6	6.3423	55.6893
2025	11	20	17	31	10	11.6	0.1	0.9	25.03	93	6.3423	52.5371
2025	11	20	17	41	10	11.6	0.1	0.9	25.51	91.8	6.3484	53.6416
2025	11	20	17	51	10	11.6	0.1	0.9	25.8	90.9	6.3484	54.2727
2025	11	20	18	1	10	11.6	0.1	0.9	26.11	91.8	6.3484	54.9038
2025	11	20	18	11	10	11.6	0.1	0.9	25.64	93.4	6.3484	53.852
2025	11	20	18	21	10	11.6	0.1	0.9	25.93	92.7	6.3484	54.4831
2025	11	20	18	31	10	11.6	0.1	0.9	26.1	90.4	6.3484	54.9038
2025	11	20	18	41	10	11.6	0.1	0.9	26.05	93.5	6.3484	54.6934
2025	11	20	18	51	10	11.6	0.1	0.9	26.75	93.4	6.3484	56.166
2025	11	20	19	1	10	11.6	0.1	0.9	25.05	93.7	6.3545	52.6425
2025	11	20	19	11	10	11.6	0.1	0.9	26.11	95.3	6.3484	54.6935
2025	11	20	19	21	10	11.6	0.1	0.9	25.64	93.4	6.3484	53.852
2025	11	20	19	31	10	11.6	0.1	0.9	26.07	94.2	6.3484	54.6935
2025	11	20	19	41	10	11.6	0.1	0.9	26.5	95	6.3484	55.5349
2025	11	20	19	51	10	11.6	0.1	0.9	25.84	93.3	6.3484	54.2728
2025	11	20	20	1	10	11.6	0.1	0.9	26.14	93.3	6.3484	54.9039
2025	11	20	20	11	10	11.6	0.1	0.9	26.22	92	6.3545	55.1694
2025	11	20	20	21	10	11.6	0.1	0.9	25.86	94	6.3484	54.2728
2025	11	20	20	31	10	11.6	0.1	0.9	25.94	93.3	6.3484	54.4832
2025	11	20	20	41	10	11.6	0.1	0.9	26.34	93	6.3484	55.3246
2025	11	20	20	51	10	11.6	0.1	0.9	25.64	93.4	6.3484	53.8521
2025	11	20	21	1	10	11.6	0.1	0.9	25.85	93.5	6.3484	54.2728
2025	11	20	21	11	10	11.6	0.1	0.9	26.13	92.9	6.3423	54.849
2025	11	20	21	21	10	11.6	0.1	0.9	25.94	93.3	6.3423	54.4287
2025	11	20	21	31	10	11.6	0.1	0.9	24.92	92.3	6.3423	52.3272
2025	11	20	21	41	10	11.6	0.1	0.9	26.38	94.3	6.3423	55.2693
2025	11	20	21	51	10	11.6	0.1	0.9	25.61	95.4	6.3423	53.5881
2025	11	20	22	1	10	11.6	0.1	0.9	26.61	91.7	6.3362	55.8437
2025	11	20	22	11	10	11.6	0.1	0.9	25.61	95.4	6.3362	53.5344
2025	11	20	22	21	10	11.6	0.1	0.9	26.11	91.8	6.3362	54.794
2025	11	20	22	31	10	11.6	0.1	0.9	25.44	93.4	6.3362	53.3244
2025	11	20	22	41	10	11.6	0.1	0.9	27.15	93.6	6.3362	56.8934
2025	11	20	22	51	10	11.6	0.1	0.9	25.27	94.3	6.3362	52.9046
2025	11	20	23	1	10	11.6	0.1	0.9	25.96	94	6.3362	54.3742
2025	11	20	23	11	10	11.6	0.1	0.9	25.48	94.5	6.3362	53.3245
2025	11	20	23	21	10	11.4	0.1	0.9	26.77	96.4	6.3362	55.8438
2025	11	20	23	31	10	11.4	0.1	0.9	26	95.1	6.3362	54.3742
2025	11	20	23	41	10	11.4	0.1	0.9	25.96	94	6.3362	54.3742
2025	11	20	23	51	10	11.4	0.1	0.9	25.95	93.5	6.3301	54.3196

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	21	0	1	10	11.4	0.1	0.9	25.13	93	6.3301	52.6418
2025	11	21	0	11	10	11.4	0.1	0.9	25.61	95.4	6.3301	53.4807
2025	11	21	0	21	10	11.4	0.1	0.9	25.95	93.5	6.3301	54.3197
2025	11	21	0	31	10	11.4	0.1	0.9	25.11	91.6	6.3301	52.6418
2025	11	21	0	41	10	11.4	0.1	0.9	26.48	94.3	6.3301	55.3683
2025	11	21	0	51	10	11.4	0.1	0.9	24.5	90.9	6.3301	51.3835
2025	11	21	1	1	10	11.4	0.1	0.9	24.81	91.8	6.3301	52.0127
2025	11	21	1	11	10	11.4	0.1	0.9	25.43	92.9	6.3301	53.271
2025	11	21	1	21	10	11.4	0.1	0.9	26.12	95.5	6.3301	54.5294
2025	11	21	1	31	10	11.4	0.1	0.9	25.61	91.8	6.3301	53.6905
2025	11	21	1	41	10	11.4	0.1	0.9	25.5	90.2	6.3301	53.4808
2025	11	21	1	51	10	11.4	0.1	0.9	25.33	92.7	6.3301	53.0613
2025	11	21	2	1	10	11.4	0.1	0.9	24.45	93.8	6.3301	51.1738
2025	11	21	2	11	10	11.4	0.1	0.9	25.93	92.9	6.324	54.2652
2025	11	21	2	21	10	11.4	0.1	0.9	26.18	94.4	6.324	54.6842
2025	11	21	2	31	10	11.4	0.1	0.9	25.46	94.1	6.324	53.2176
2025	11	21	2	41	10	11.4	0.1	0.9	25.24	93.2	6.324	52.7985
2025	11	21	2	51	10	11.4	0.1	0.9	25.45	93.6	6.324	53.2176
2025	11	21	3	1	10	11.4	0.1	0.9	26.33	92.6	6.324	55.1033
2025	11	21	3	11	10	11.4	0.1	0.9	25.05	93.7	6.324	52.3795
2025	11	21	3	21	10	11.4	0.1	0.9	24.93	95.8	6.324	51.9605
2025	11	21	3	31	10	11.4	0.1	0.9	25.22	95.7	6.324	52.5891
2025	11	21	3	41	10	11.4	0.1	0.9	26.32	92	6.324	55.1033
2025	11	21	3	51	10	11.4	0.1	0.9	24.65	93.5	6.324	51.5415
2025	11	21	4	1	10	11.4	0.1	0.9	25.02	92.1	6.3179	52.3269
2025	11	21	4	11	10	11.4	0.1	0.9	25.68	94.5	6.3179	53.5827
2025	11	21	4	21	10	11.4	0.1	0.9	26.97	94	6.324	56.3604
2025	11	21	4	31	10	11.4	0.1	0.9	25.12	92.3	6.324	52.5891
2025	11	21	4	41	10	11.4	0.1	0.9	24.65	93.5	6.3179	51.4897
2025	11	21	4	51	10	11.4	0.1	0.9	24.84	93.2	6.3179	51.9083
2025	11	21	5	1	10	11.4	0.1	0.9	25.56	93.8	6.3179	53.3734
2025	11	21	5	11	10	11.4	0.1	0.9	24.87	94.4	6.3179	51.9083
2025	11	21	5	21	10	11.4	0.1	0.9	26.32	92.4	6.3179	55.0479
2025	11	21	5	31	10	11.4	0.1	0.9	25.76	94	6.3179	53.792
2025	11	21	5	41	10	11.4	0.1	0.9	26.16	93.7	6.3179	54.6293
2025	11	21	5	51	10	11.4	0.1	0.9	26.13	92.6	6.3179	54.6293
2025	11	21	6	1	10	11.4	0.1	0.9	25.14	93.4	6.3179	52.5362
2025	11	21	6	11	10	11.4	0.1	0.9	24.96	94.1	6.3179	52.1176
2025	11	21	6	21	10	11.4	0.1	0.9	25.76	93.8	6.3179	53.7921
2025	11	21	6	31	10	11.4	0.1	0.9	26.06	93.7	6.3179	54.42
2025	11	21	6	41	10	11.4	0.1	0.9	25.32	92.5	6.3179	52.9548
2025	11	21	6	51	10	11.4	0.1	0.9	25.25	93.6	6.3179	52.7455
2025	11	21	7	1	10	11.4	0.1	0.9	25.62	95.6	6.3179	53.3734
2025	11	21	7	11	10	11.4	0.1	0.9	26.01	95.3	6.3179	54.2107
2025	11	21	7	21	10	11.4	0.1	0.9	24.91	95.3	6.3179	51.9083
2025	11	21	7	31	10	11.4	0.1	0.9	25.34	93.2	6.3179	52.9548
2025	11	21	7	41	10	11.4	0.1	0.9	24.82	92.3	6.3179	51.9083
2025	11	21	7	51	10	11.4	0.1	0.9	24.18	94.7	6.3179	50.4432

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	21	8	1	10	11.4	0.1	0.9	25.2	90.9	6.3179	52.7455
2025	11	21	8	11	10	11.4	0.1	0.9	25.86	96.4	6.3179	53.7921
2025	11	21	8	21	10	11.4	0.1	0.9	26.28	94.6	6.3179	54.8386
2025	11	21	8	31	10	11.4	0.1	0.9	25.76	94	6.3179	53.7921
2025	11	21	8	41	10	11.4	0.1	0.9	25.57	94.3	6.3118	53.3198
2025	11	21	8	51	10	11.4	0.1	0.9	25.33	92.9	6.3179	52.9548
2025	11	21	9	1	10	11.4	0.1	0.9	24.44	93.3	6.3179	51.0711
2025	11	21	9	11	10	11.4	0.1	0.9	26.14	95.9	6.3179	54.42
2025	11	21	9	21	10	11.4	0.1	0.9	26.01	91.8	6.3118	54.3652
2025	11	21	9	31	10	11.4	0.1	0.9	25.96	94	6.3179	54.2107
2025	11	21	9	41	10	11.4	0.1	0.9	25.69	94.7	6.3179	53.5828
2025	11	21	9	51	10	11.4	0.1	0.9	25.85	93.5	6.3179	54.0014
2025	11	21	10	1	10	11.4	0.1	0.9	26.03	92.6	6.3179	54.42
2025	11	21	10	11	10	11.4	0.1	0.9	24.01	91.9	6.3179	50.2339
2025	11	21	10	21	10	11.4	0.1	0.9	25.39	94.7	6.3179	52.9548
2025	11	21	10	31	10	11.6	0.1	0.9	24.35	93.8	6.3118	50.8106
2025	11	21	10	41	10	11.6	0.1	0.9	25.36	96.3	6.3179	52.7455
2025	11	21	10	51	10	11.6	0.1	0.9	23.94	93.4	6.3118	49.9742
2025	11	21	11	1	10	11.6	0.1	0.9	25.94	93.3	6.3179	54.2107
2025	11	21	11	11	10	11.6	0.1	0.9	26.13	92.6	6.3179	54.6293
2025	11	21	11	21	10	11.4	0.1	0.9	25.02	92.5	6.3179	52.3269
2025	11	21	11	31	10	11.4	0.1	0.9	25.75	93.6	6.3179	53.7921
2025	11	21	11	41	10	11.6	0.1	0.9	25.7	95.1	6.3179	53.5827
2025	11	21	11	51	10	11.6	0.1	0.9	24.65	93.5	6.3179	51.4896
2025	11	21	12	1	10	11.6	0.1	0.9	25.22	92.5	6.3179	52.7455
2025	11	21	12	11	10	11.4	0.1	0.9	25.96	94	6.3179	54.2106
2025	11	21	12	21	10	11.6	0.1	0.9	24.95	93.7	6.3179	52.1175
2025	11	21	12	31	10	11.6	0.1	0.9	25.51	91.3	6.3179	53.3734
2025	11	21	12	41	10	11.6	0.1	0.9	25.33	92.7	6.3179	52.9548
2025	11	21	12	51	10	11.6	0.1	0.9	25.71	95.4	6.3179	53.5827
2025	11	21	13	1	10	11.6	0.1	0.9	25.55	96.3	6.3179	53.1641
2025	11	21	13	11	10	11.4	0.1	0.9	25.72	92.5	6.3179	53.792
2025	11	21	13	21	10	11.4	0.1	0.9	25.15	93.6	6.3179	52.5361
2025	11	21	13	31	10	11.6	0.1	0.9	24.72	92.1	6.3179	51.6989
2025	11	21	13	41	10	11.6	0.1	0.9	25.21	91.8	6.3179	52.7454
2025	11	21	13	51	10	11.6	0.1	0.9	24.42	92.6	6.3179	51.071
2025	11	21	14	1	10	11.6	0.1	0.9	25.44	93.4	6.3179	53.1641
2025	11	21	14	11	10	11.6	0.1	0.9	23.36	94.2	6.3179	48.7686
2025	11	21	14	21	10	11.4	0.1	0.9	26.28	94.6	6.3179	54.8385
2025	11	21	14	31	10	11.4	0.1	0.9	25.71	95.4	6.3179	53.5827
2025	11	21	14	41	10	11.4	0.1	0.9	25.45	93.6	6.3179	53.1641
2025	11	21	14	51	10	11.4	0.1	0.9	25.45	93.6	6.3179	53.1641
2025	11	21	15	1	10	11.4	0.1	0.9	25.39	94.7	6.3179	52.9548
2025	11	21	15	11	10	11.4	0.1	0.9	24.91	91.8	6.3179	52.1175
2025	11	21	15	21	10	11.4	0.1	0.9	25.57	96.5	6.3179	53.1641
2025	11	21	15	31	10	11.4	0.1	0.9	25.62	95.6	6.3179	53.3734
2025	11	21	15	41	10	11.4	0.1	0.9	25.27	94.3	6.3179	52.7454
2025	11	21	15	51	10	11.4	0.1	0.9	25.1	95	6.3179	52.3268

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	21	16	1	10	11.4	0.1	0.9	25.86	93.8	6.3179	54.0013
2025	11	21	16	11	10	11.4	0.1	0.9	24.82	92.5	6.3179	51.9082
2025	11	21	16	21	10	11.4	0.1	0.9	25.35	93.6	6.3179	52.9548
2025	11	21	16	31	10	11.4	0.1	0.9	25.3	91.1	6.3118	52.9015
2025	11	21	16	41	10	11.4	0.1	0.9	26.18	94.4	6.3118	54.5742
2025	11	21	16	51	10	11.4	0.1	0.9	24.52	92.1	6.3179	51.2803
2025	11	21	17	1	10	11.4	0.1	0.9	26.3	95	6.3179	54.8385
2025	11	21	17	11	10	11.4	0.1	0.9	25.39	94.7	6.3118	52.9015
2025	11	21	17	21	10	11.4	0.1	0.9	25.32	92.3	6.3179	52.9548
2025	11	21	17	31	10	11.4	0.1	0.9	24.87	94.2	6.3118	51.856
2025	11	21	17	41	10	11.4	0.1	0.9	25.16	94.1	6.3179	52.5362
2025	11	21	17	51	10	11.4	0.1	0.9	26.09	94.8	6.3118	54.3652
2025	11	21	18	1	10	11.4	0.1	0.9	24.95	93.7	6.3118	52.0651
2025	11	21	18	11	10	11.4	0.1	0.9	25.65	93.6	6.3118	53.5288
2025	11	21	18	21	10	11.4	0.1	0.9	25.22	92.5	6.3118	52.6924
2025	11	21	18	31	10	11.4	0.1	0.9	25.53	95.8	6.3118	53.1106
2025	11	21	18	41	10	11.4	0.1	0.9	26	95.1	6.3118	54.1561
2025	11	21	18	51	10	11.4	0.1	0.9	25.27	94.3	6.3118	52.6924
2025	11	21	19	1	10	11.4	0.1	0.9	25.33	92.7	6.3118	52.9015
2025	11	21	19	11	10	11.4	0.1	0.9	25.29	94.8	6.3118	52.6924
2025	11	21	19	21	10	11.4	0.1	0.9	25.19	94.8	6.3118	52.4833
2025	11	21	19	31	10	11.4	0.1	0.9	26.18	94.4	6.3118	54.5743
2025	11	21	19	41	10	11.4	0.1	0.9	25.48	94.5	6.3118	53.1106
2025	11	21	19	51	10	11.4	0.1	0.9	25.85	93.5	6.3118	53.947
2025	11	21	20	1	10	11.4	0.1	0.9	24.89	94.8	6.3118	51.8561
2025	11	21	20	11	10	11.4	0.1	0.9	24.48	94.7	6.3118	51.0197
2025	11	21	20	21	10	11.4	0.1	0.9	24.42	92.1	6.3118	51.0197
2025	11	21	20	31	10	11.4	0.1	0.9	25.68	96.7	6.3118	53.3198
2025	11	21	20	41	10	11.4	0.1	0.9	24.85	93.7	6.3118	51.8561
2025	11	21	20	51	10	11.4	0.1	0.9	25.19	94.8	6.3118	52.4834
2025	11	21	21	1	10	11.4	0.1	0.9	25.06	93.9	6.3057	52.2216
2025	11	21	21	11	10	11.4	0.1	0.9	25.43	92.7	6.3057	53.0572
2025	11	21	21	21	10	11.4	0.1	0.9	24.81	91.8	6.3057	51.8039
2025	11	21	21	31	10	11.4	0.1	0.9	26.28	94.6	6.3057	54.7283
2025	11	21	21	41	10	11.4	0.1	0.9	24.84	93.2	6.3057	51.8039
2025	11	21	21	51	10	11.4	0.1	0.9	25.07	94.3	6.3057	52.2217
2025	11	21	22	1	10	11.4	0.1	0.9	25.22	92.3	6.3057	52.6395
2025	11	21	22	11	10	11.4	0.1	0.9	25.78	94.4	6.3057	53.6839
2025	11	21	22	21	10	11.4	0.1	0.9	26.87	94.1	6.3057	55.9817
2025	11	21	22	31	10	11.4	0.1	0.9	24.93	95.8	6.3057	51.8039
2025	11	21	22	41	10	11.4	0.1	0.9	25.63	92.9	6.2996	53.4211
2025	11	21	22	51	10	11.4	0.1	0.9	24.71	95.3	6.3057	51.3862
2025	11	21	23	1	10	11.4	0.1	0.9	26.05	96.2	6.3057	54.1017
2025	11	21	23	11	10	11.4	0.1	0.9	25.67	94.2	6.2996	53.4211
2025	11	21	23	21	10	11.4	0.1	0.9	25.03	92.7	6.2996	52.1691
2025	11	21	23	31	10	11.4	0.1	0.9	26.02	92.2	6.2996	54.2558
2025	11	21	23	41	10	11.4	0.1	0.9	25.57	94.3	6.2996	53.2125
2025	11	21	23	51	10	11.4	0.1	0.9	24.75	93.7	6.2996	51.5431

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	22	0	1	10	11.4	0.1	0.9	25.48	94.5	6.2996	53.0038
2025	11	22	0	11	10	11.4	0.1	0.9	25.01	95.3	6.2996	51.9604
2025	11	22	0	21	10	11.4	0.1	0.9	25.64	96	6.2996	53.2125
2025	11	22	0	31	10	11.4	0.1	0.9	25.76	94	6.2996	53.6298
2025	11	22	0	41	10	11.4	0.1	0.9	25.59	94.7	6.2996	53.2125
2025	11	22	0	51	10	11.4	0.1	0.9	24.86	96.5	6.2935	51.491
2025	11	22	1	1	10	11.4	0.1	0.9	24.32	95.7	6.2996	50.4997
2025	11	22	1	11	10	11.4	0.1	0.9	25.53	92.7	6.2935	53.1588
2025	11	22	1	21	10	11.4	0.1	0.9	25.65	93.6	6.2935	53.3672
2025	11	22	1	31	10	11.4	0.1	0.9	25.71	95.4	6.2935	53.3672
2025	11	22	1	41	10	11.4	0.1	0.9	25.41	91.8	6.2935	52.9503
2025	11	22	1	51	10	11.4	0.1	0.9	25.8	95.1	6.2935	53.5757
2025	11	22	2	1	10	11.4	0.1	0.9	25.01	95.3	6.2935	51.908
2025	11	22	2	11	10	11.4	0.1	0.9	25.2	95	6.2935	52.3249
2025	11	22	2	21	10	11.4	0.1	0.9	25.03	95.7	6.2935	51.908
2025	11	22	2	31	10	11.4	0.1	0.9	26.03	92.9	6.2935	54.2011
2025	11	22	2	41	10	11.4	0.1	0.9	24.29	95	6.2935	50.4488
2025	11	22	2	51	10	11.4	0.1	0.9	24.35	93.5	6.2935	50.6572
2025	11	22	3	1	10	11.4	0.1	0.9	25.33	95.9	6.2874	52.4803
2025	11	22	3	11	10	11.4	0.1	0.9	24.77	94.4	6.2874	51.4391
2025	11	22	3	21	10	11.4	0.1	0.9	25.53	95.8	6.2874	52.8968
2025	11	22	3	31	10	11.4	0.1	0.9	23.53	96.1	6.2874	48.7317
2025	11	22	3	41	10	11.4	0.1	0.9	25.54	93.1	6.2874	53.1051
2025	11	22	3	51	10	11.4	0.1	0.9	24.96	94.1	6.2874	51.8556
2025	11	22	4	1	10	11.4	0.1	0.9	25.05	93.7	6.2813	52.0112
2025	11	22	4	11	10	11.4	0.1	0.9	26.08	94.6	6.2874	54.1464
2025	11	22	4	21	10	11.4	0.1	0.9	25.09	94.8	6.2813	52.0112
2025	11	22	4	31	10	11.4	0.1	0.9	26.19	94.8	6.2813	54.2997
2025	11	22	4	41	10	11.4	0.1	0.9	24.39	97.1	6.2752	50.2959
2025	11	22	4	51	10	11.4	0.1	0.9	25.2	95	6.2752	52.1664
2025	11	22	5	1	10	11.4	0.1	0.9	24.55	93.7	6.2691	50.8678
2025	11	22	5	11	10	11.4	0.1	0.9	24.62	92.3	6.2691	51.0754
2025	11	22	5	21	10	11.4	0.1	0.9	25.63	92.9	6.2752	53.2056
2025	11	22	5	31	10	11.4	0.1	0.9	26.11	95.3	6.2752	54.0369
2025	11	22	5	41	10	11.4	0.1	0.9	24.39	94.9	6.2691	50.4525
2025	11	22	5	51	10	11.4	0.1	0.9	24.43	95.9	6.2691	50.4525
2025	11	22	6	1	10	11.4	0.1	0.9	24.93	95.8	6.2691	51.4907
2025	11	22	6	11	10	11.4	0.1	0.9	23.56	94.1	6.2752	48.8411
2025	11	22	6	21	10	11.4	0.1	0.9	24.82	92.5	6.2691	51.4907
2025	11	22	6	31	10	11.4	0.1	0.9	24.75	93.5	6.263	51.231
2025	11	22	6	41	10	11.4	0.1	0.9	24.49	94.9	6.263	50.6088
2025	11	22	6	51	10	11.4	0.1	0.9	24.32	92.1	6.263	50.4014
2025	11	22	7	1	10	11.4	0.1	0.9	25.17	96.6	6.263	51.8533
2025	11	22	7	11	10	11.4	0.1	0.9	24.15	93.8	6.2691	50.0373
2025	11	22	7	21	10	11.4	0.1	0.9	24.79	94.9	6.2691	51.2831
2025	11	22	7	31	10	11.4	0.1	0.9	23.53	92.9	6.263	48.7421
2025	11	22	7	41	10	11.4	0.1	0.9	25.22	95.7	6.263	52.0607
2025	11	22	7	51	10	11.4	0.1	0.9	24.24	93.3	6.2569	50.143

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	22	8	1	10	11.4	0.1	0.9	25.48	94.5	6.2569	52.6295
2025	11	22	8	11	10	11.4	0.1	0.9	25.41	91.8	6.2569	52.6294
2025	11	22	8	21	10	11.4	0.1	0.9	26.19	94.8	6.2569	54.0799
2025	11	22	8	31	10	11.4	0.1	0.9	24.27	94.5	6.2569	50.143
2025	11	22	8	41	10	11.4	0.1	0.9	25.3	95.2	6.2569	52.215
2025	11	22	8	51	10	11.4	0.1	0.9	25.48	94.5	6.2569	52.6294
2025	11	22	9	1	10	11.4	0.1	0.9	24.14	93.1	6.2569	49.9358
2025	11	22	9	11	10	11.4	0.1	0.9	24.63	95.8	6.2569	50.7646
2025	11	22	9	21	10	11.4	0.1	0.9	24.75	93.5	6.2569	51.179
2025	11	22	9	31	10	11.4	0.1	0.9	24.55	93.7	6.2569	50.7646
2025	11	22	9	41	10	11.4	0.1	0.9	25.79	94.7	6.2569	53.2511
2025	11	22	9	51	10	11.4	0.1	0.9	25.25	93.6	6.2569	52.215
2025	11	22	10	1	10	11.4	0.1	0.9	23.83	92.9	6.2569	49.3142
2025	11	22	10	11	10	11.4	0.1	0.9	24.57	94.4	6.2569	50.7646
2025	11	22	10	21	10	11.6	0.1	0.9	25.66	93.8	6.2569	53.0438
2025	11	22	10	31	10	11.8	0.1	0.9	25.46	94.1	6.2569	52.6294
2025	11	22	10	41	10	11.6	0.1	0.9	24.72	92.5	6.2508	51.127
2025	11	22	10	51	10	11.6	0.1	0.9	24.68	94.6	6.2569	50.9718
2025	11	22	11	1	10	11.6	0.1	0.9	23.78	94.6	6.2569	49.107
2025	11	22	11	11	10	11.6	0.1	0.9	23.72	92.2	6.2569	49.1069
2025	11	22	11	21	10	11.6	0.1	0.9	25.14	93.4	6.2508	51.9549
2025	11	22	11	31	10	11.6	0.1	0.9	23.95	93.6	6.2569	49.5213
2025	11	22	11	41	10	11.6	0.1	0.9	24.45	96.3	6.2569	50.3501
2025	11	22	11	51	10	11.6	0.1	0.9	26.23	92.8	6.2569	54.287
2025	11	22	12	1	10	11.6	0.1	0.9	25.36	93.8	6.2569	52.4221
2025	11	22	12	11	10	11.6	0.1	0.9	24.55	93.7	6.2569	50.7645
2025	11	22	12	21	10	11.6	0.1	0.9	25.41	95.4	6.2569	52.4221
2025	11	22	12	31	10	11.6	0.1	0.9	25.06	93.9	6.2569	51.8005
2025	11	22	12	41	10	11.6	0.1	0.9	24.86	93.9	6.2569	51.3861
2025	11	22	12	51	10	11.6	0.1	0.9	24.55	93.7	6.2569	50.7644
2025	11	22	13	1	10	11.8	0.1	0.9	24.35	93.8	6.2569	50.35
2025	11	22	13	11	10	11.8	0.1	0.9	25.89	96.9	6.2569	53.2508
2025	11	22	13	21	10	11.8	0.1	0.9	25.55	96.3	6.2569	52.6292
2025	11	22	13	31	10	11.8	0.1	0.9	26.61	95.2	6.2569	54.9084
2025	11	22	13	41	10	11.8	0.1	0.9	24.74	93.2	6.2569	51.1788
2025	11	22	13	51	10	11.8	0.1	0.9	25.26	93.9	6.2569	52.2148
2025	11	22	14	1	10	11.8	0.1	0.9	25.57	94.3	6.2569	52.8364
2025	11	22	14	11	10	11.8	0.1	0.9	24.85	93.7	6.2569	51.3859
2025	11	22	14	21	10	11.8	0.1	0.9	25.75	93.6	6.2569	53.2507
2025	11	22	14	31	10	11.8	0.1	0.9	24.15	93.8	6.2569	49.9355
2025	11	22	14	41	10	12	0.1	0.9	26.92	95.3	6.2569	55.5299
2025	11	22	14	51	10	12.4	0.1	0.9	24.65	93.5	6.2569	50.9714
2025	11	22	15	1	10	11.8	0.1	0.9	25.41	91.8	6.2569	52.629
2025	11	22	15	11	10	11.8	0.1	0.9	24.27	94.5	6.2569	50.1426
2025	11	22	15	21	10	11.8	0.1	0.9	24.57	96.8	6.2569	50.557
2025	11	22	15	31	10	12	0.1	0.9	25.46	94.1	6.2569	52.6289
2025	11	22	15	41	10	11.8	0.1	0.9	24.77	94.4	6.2569	51.1785
2025	11	22	15	51	10	12	0.1	0.9	25.22	95.7	6.2569	52.0073

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	22	16	1	10	11.8	0.1	0.9	25.22	92.5	6.2569	52.2145
2025	11	22	16	11	10	11.8	0.1	0.9	24.23	92.8	6.2569	50.1425
2025	11	22	16	21	10	11.8	0.1	0.9	25.09	94.8	6.2569	51.8001
2025	11	22	16	31	10	12	0.1	0.9	24.97	94.4	6.2569	51.5929
2025	11	22	16	41	10	11.8	0.1	0.9	24.58	94.7	6.2569	50.7641
2025	11	22	16	51	10	11.8	0.1	0.9	24.85	93.7	6.2569	51.3857
2025	11	22	17	1	10	11.6	0.1	0.9	24.98	94.6	6.2569	51.5929
2025	11	22	17	11	10	11.6	0.1	0.9	26.23	92.6	6.2569	54.2864
2025	11	22	17	21	10	11.6	0.1	0.9	25.14	93.4	6.2569	52.0072
2025	11	22	17	31	10	11.6	0.1	0.9	25.55	93.6	6.2569	52.836
2025	11	22	17	41	10	11.6	0.1	0.9	25.18	94.6	6.2569	52.0072
2025	11	22	17	51	10	11.6	0.1	0.9	25.03	92.7	6.2569	51.8
2025	11	22	18	1	10	11.6	0.1	0.9	24.85	96.2	6.2569	51.1784
2025	11	22	18	11	10	11.6	0.1	0.9	24.32	92.4	6.2569	50.3496
2025	11	22	18	21	10	11.6	0.1	0.9	25.47	96.5	6.2569	52.4216
2025	11	22	18	31	10	11.4	0.1	0.9	25.75	93.6	6.2569	53.2504
2025	11	22	18	41	10	11.4	0.1	0.9	24.08	94.8	6.2569	49.728
2025	11	22	18	51	10	11.4	0.1	0.9	24.47	94.5	6.2569	50.5568
2025	11	22	19	1	10	11.4	0.1	0.9	25.43	92.9	6.2569	52.6289
2025	11	22	19	11	10	11.4	0.1	0.9	25.79	94.9	6.2569	53.2505
2025	11	22	19	21	10	11.4	0.1	0.9	25.79	94.9	6.2569	53.2505
2025	11	22	19	31	10	11.4	0.1	0.9	24.18	94.7	6.2569	49.9353
2025	11	22	19	41	10	11.4	0.1	0.9	24.74	93.2	6.2569	51.1785
2025	11	22	19	51	10	11.4	0.1	0.9	25.14	93.4	6.2569	52.0073
2025	11	22	20	1	10	11.4	0.1	0.9	24.87	94.2	6.2569	51.3857
2025	11	22	20	11	10	11.4	0.1	0.9	25.33	92.7	6.2569	52.4217
2025	11	22	20	21	10	11.4	0.1	0.9	24.76	96.5	6.2569	50.9713
2025	11	22	20	31	10	11.4	0.1	0.9	24.93	93	6.2569	51.593
2025	11	22	20	41	10	11.4	0.1	0.9	25.5	95.2	6.2569	52.629
2025	11	22	20	51	10	11.4	0.1	0.9	24.52	95.6	6.2569	50.557
2025	11	22	21	1	10	11.4	0.1	0.9	25.66	94	6.2569	53.0434
2025	11	22	21	11	10	11.4	0.1	0.9	23.64	93.2	6.2569	48.8994
2025	11	22	21	21	10	11.4	0.1	0.9	24.5	95.2	6.2569	50.557
2025	11	22	21	31	10	11.4	0.1	0.9	24.29	95	6.2569	50.1427
2025	11	22	21	41	10	11.4	0.1	0.9	25.5	95.2	6.2569	52.6291
2025	11	22	21	51	10	11.4	0.1	0.9	23.89	95	6.2569	49.3139
2025	11	22	22	1	10	11.4	0.1	0.9	25.93	92.7	6.2569	53.6651
2025	11	22	22	11	10	11.4	0.1	0.9	25.74	93.1	6.2569	53.2507
2025	11	22	22	21	10	11.4	0.1	0.9	24.95	93.7	6.2508	51.5407
2025	11	22	22	31	10	11.4	0.1	0.9	24.63	93	6.2569	50.9716
2025	11	22	22	41	10	11.4	0.1	0.9	24.93	92.8	6.2508	51.5408
2025	11	22	22	51	10	11.4	0.1	0.9	25.25	93.6	6.2508	52.1617
2025	11	22	23	1	10	11.4	0.1	0.9	26.08	94.4	6.2508	53.8177
2025	11	22	23	11	10	11.4	0.1	0.9	23.99	95	6.2508	49.4709
2025	11	22	23	21	10	11.4	0.1	0.9	24.85	96.2	6.2508	51.1269
2025	11	22	23	31	10	11.4	0.1	0.9	25.79	94.7	6.2508	53.1968
2025	11	22	23	41	10	11.4	0.1	0.9	24.09	95	6.2508	49.678
2025	11	22	23	51	10	11.4	0.1	0.9	25.42	95.6	6.2508	52.3689

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	23	0	1	10	11.4	0.1	0.9	24.85	96.2	6.2508	51.1269
2025	11	23	0	11	10	11.4	0.1	0.9	25.25	93.6	6.2508	52.1619
2025	11	23	0	21	10	11.4	0.1	0.9	25.68	94.5	6.2508	52.9899
2025	11	23	0	31	10	11.4	0.1	0.9	24.44	96.1	6.2508	50.299
2025	11	23	0	41	10	11.4	0.1	0.9	24.76	93.9	6.2508	51.127
2025	11	23	0	51	10	11.4	0.1	0.9	24.86	93.9	6.2508	51.334
2025	11	23	1	1	10	11.4	0.1	0.9	25.12	92.5	6.2508	51.955
2025	11	23	1	11	10	11.4	0.1	0.9	24.25	93.8	6.2508	50.0921
2025	11	23	1	21	10	11.4	0.1	0.9	25.26	94.1	6.2508	52.1621
2025	11	23	1	31	10	11.4	0.1	0.9	24.14	93.1	6.2508	49.8852
2025	11	23	1	41	10	11.4	0.1	0.9	24.53	95.9	6.2508	50.5062
2025	11	23	1	51	10	11.4	0.1	0.9	24.65	96.3	6.2508	50.7132
2025	11	23	2	1	10	11.4	0.1	0.9	26.35	96.1	6.2508	54.2321
2025	11	23	2	11	10	11.4	0.1	0.9	24.63	92.8	6.2508	50.9202
2025	11	23	2	21	10	11.4	0.1	0.9	24.9	95.1	6.2508	51.3342
2025	11	23	2	31	10	11.4	0.1	0.9	25.91	95.3	6.2508	53.4042
2025	11	23	2	41	10	11.4	0.1	0.9	24.37	94.5	6.2508	50.2993
2025	11	23	2	51	10	11.4	0.1	0.9	24.89	94.8	6.2508	51.3343
2025	11	23	3	1	10	11.2	0.1	0.9	24.37	94.5	6.2508	50.2993
2025	11	23	3	11	10	11.2	0.1	0.9	25.23	93	6.2508	52.1623
2025	11	23	3	21	10	11.2	0.1	0.9	24.61	91.9	6.2508	50.9204
2025	11	23	3	31	10	11.2	0.1	0.9	24.27	96.9	6.2508	49.8854
2025	11	23	3	41	10	11.2	0.1	0.9	25.9	95.1	6.2447	53.35
2025	11	23	3	51	10	11.2	0.1	0.9	23.89	95	6.2447	49.2144
2025	11	23	4	1	10	11.2	0.1	0.9	24.99	94.8	6.2447	51.489
2025	11	23	4	11	10	11.2	0.1	0.9	26.57	94.1	6.2447	54.7975
2025	11	23	4	21	10	11.2	0.1	0.9	25.19	94.8	6.2447	51.9026
2025	11	23	4	31	10	11.2	0.1	0.9	26.18	94.4	6.2447	53.9704
2025	11	23	4	41	10	11.2	0.1	0.9	25.85	96.2	6.2447	53.1433
2025	11	23	4	51	10	11.2	0.1	0.9	26.01	91.8	6.2447	53.7637
2025	11	23	5	1	10	11.2	0.1	0.9	25.5	95	6.2447	52.523
2025	11	23	5	11	10	11.2	0.1	0.9	24.58	94.7	6.2447	50.662
2025	11	23	5	21	10	11.2	0.1	0.9	25.12	95.7	6.2447	51.6959
2025	11	23	5	31	10	11.2	0.1	0.9	24.66	94	6.2447	50.8688
2025	11	23	5	41	10	11.2	0.1	0.9	24.81	95.3	6.2447	51.0756
2025	11	23	5	51	10	11.2	0.1	0.9	25.3	97.3	6.2447	51.9027
2025	11	23	6	1	10	11.2	0.1	0.9	25.04	93.4	6.2447	51.696
2025	11	23	6	11	10	11.2	0.1	0.9	24.49	94.9	6.2447	50.4553
2025	11	23	6	21	10	11.2	0.1	0.9	25.08	96.9	6.2447	51.4892
2025	11	23	6	31	10	11.2	0.1	0.9	24.13	92.9	6.2447	49.835
2025	11	23	6	41	10	11.2	0.1	0.9	24.5	95.2	6.2447	50.4553
2025	11	23	6	51	10	11.2	0.1	0.9	25.03	95.7	6.2386	51.4368
2025	11	23	7	1	10	11.2	0.1	0.9	25.31	95.4	6.2447	52.1096
2025	11	23	7	11	10	11.2	0.1	0.9	24.93	95.8	6.2386	51.2303
2025	11	23	7	21	10	11.2	0.1	0.9	24.55	93.5	6.2386	50.6106
2025	11	23	7	31	10	11.2	0.1	0.9	25.17	94.3	6.2386	51.85
2025	11	23	7	41	10	11.2	0.1	0.9	24.73	97.9	6.2386	50.6106
2025	11	23	7	51	10	11.2	0.1	0.9	24.39	94.9	6.2386	50.1975

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	23	8	1	10	11.2	0.1	0.9	25.34	93.4	6.2386	52.2632
2025	11	23	8	11	10	11.2	0.1	0.9	25.89	94.7	6.2386	53.2961
2025	11	23	8	21	10	11.2	0.1	0.9	24.99	94.8	6.2386	51.437
2025	11	23	8	31	10	11.6	0.1	0.9	25.21	95.5	6.2386	51.8501
2025	11	23	8	41	10	11.8	0.1	0.9	24.63	92.8	6.2386	50.8173
2025	11	23	8	51	10	12	0.1	0.9	25.58	94.5	6.2386	52.6764
2025	11	23	9	1	10	12	0.1	0.9	24.08	94.8	6.2386	49.5778
2025	11	23	9	11	10	12	0.1	0.9	23.83	92.6	6.2386	49.1647
2025	11	23	9	21	10	12.2	0.1	0.9	24.35	93.8	6.2386	50.1975
2025	11	23	9	31	10	12.2	0.1	0.9	24.32	92.6	6.2386	50.1975
2025	11	23	9	41	10	12.2	0.1	0.9	24.95	93.7	6.2386	51.437
2025	11	23	9	51	10	12.2	0.1	0.9	24.72	95.6	6.2386	50.8172
2025	11	23	10	1	10	12.6	0.1	0.9	24.85	93.5	6.2386	51.2304
2025	11	23	10	11	10	12.4	0.1	0.9	25.93	95.8	6.2386	53.2961
2025	11	23	10	21	10	12.4	0.1	0.9	25.32	95.7	6.2386	52.0566
2025	11	23	10	31	10	12.6	0.1	0.9	24.55	93.7	6.2386	50.6106
2025	11	23	10	41	10	12.6	0.1	0.9	24.87	94.2	6.2386	51.2303
2025	11	23	10	51	10	12.6	0.1	0.9	25.21	95.5	6.2386	51.8499
2025	11	23	11	1	10	12.4	0.1	0.9	24.53	93	6.2386	50.6105
2025	11	23	11	11	10	12.4	0.1	0.9	24.92	95.5	6.2386	51.2302
2025	11	23	11	21	10	12.6	0.1	0.9	24.91	91.6	6.2386	51.4367
2025	11	23	11	31	10	12.6	0.1	0.9	24.05	93.8	6.2386	49.5775
2025	11	23	11	41	10	12.6	0.1	0.9	25.32	92.3	6.2386	52.2629
2025	11	23	11	51	10	12.6	0.1	0.9	24.69	94.9	6.2386	50.8169
2025	11	23	12	1	10	12.4	0.1	0.9	24.81	97.4	6.2386	50.8168
2025	11	23	12	11	10	12.4	0.1	0.9	24.27	96.9	6.2386	49.7839
2025	11	23	12	21	10	12.6	0.1	0.9	25.03	93	6.2386	51.643
2025	11	23	12	31	10	12.6	0.1	0.9	25.91	95.3	6.2386	53.2956
2025	11	23	12	41	10	12.6	0.1	0.9	25.49	94.7	6.2386	52.4692
2025	11	23	12	51	10	12.6	0.1	0.9	25.13	95.9	6.2386	51.6429
2025	11	23	13	1	10	12.4	0.1	0.9	25.21	95.5	6.2386	51.8494
2025	11	23	13	11	10	12.6	0.1	0.9	24.57	94.4	6.2386	50.6099
2025	11	23	13	21	10	12.6	0.1	0.9	24.98	94.6	6.2386	51.4362
2025	11	23	13	31	10	12.6	0.1	0.9	25.29	94.8	6.2386	52.0559
2025	11	23	13	41	10	12.4	0.1	0.9	25.21	95.5	6.2386	51.8493
2025	11	23	13	51	10	12.4	0.1	0.9	25.18	94.6	6.2386	51.8492
2025	11	23	14	1	10	12.4	0.1	0.9	26.61	95.2	6.2447	54.797
2025	11	23	14	11	10	12.4	0.1	0.9	25.53	95.8	6.2447	52.5223
2025	11	23	14	21	10	12.4	0.1	0.9	25.48	94.5	6.2447	52.5223
2025	11	23	14	31	10	12.4	0.1	0.9	24.65	93.7	6.2447	50.868
2025	11	23	14	41	10	12.4	0.1	0.9	25.23	92.7	6.2447	52.1087
2025	11	23	14	51	10	12.4	0.1	0.9	25.87	94.2	6.2447	53.3494
2025	11	23	15	1	10	12.4	0.1	0.9	25.31	95.4	6.2447	52.1087
2025	11	23	15	11	10	12.6	0.1	0.9	24.89	94.8	6.2447	51.2815
2025	11	23	15	21	10	12.6	0.1	0.9	25.44	96.1	6.2447	52.3154
2025	11	23	15	31	10	12.6	0.1	0.9	24.85	93.5	6.2447	51.2815
2025	11	23	15	41	10	12.6	0.1	0.9	25.72	95.6	6.2447	52.9357
2025	11	23	15	51	10	12.6	0.1	0.9	24.47	94.2	6.2447	50.4543

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	23	16	1	10	12.2	0.1	0.9	24.26	94	6.2447	50.0408
2025	11	23	16	11	10	12.2	0.1	0.9	24.82	95.5	6.2447	51.0746
2025	11	23	16	21	10	12.2	0.1	0.9	25.55	96.3	6.2447	52.5221
2025	11	23	16	31	10	12.2	0.1	0.9	25.16	94.1	6.2447	51.9017
2025	11	23	16	41	10	12	0.1	0.9	25.19	94.8	6.2447	51.9017
2025	11	23	16	51	10	12	0.1	0.9	25.92	92.2	6.2447	53.556
2025	11	23	17	1	10	12	0.1	0.9	25.53	92.7	6.2447	52.7288
2025	11	23	17	11	10	11.8	0.1	0.9	24.13	95.9	6.2447	49.6271
2025	11	23	17	21	10	11.8	0.1	0.9	24.99	94.8	6.2447	51.4881
2025	11	23	17	31	10	11.8	0.1	0.9	23.65	93.9	6.2447	48.8
2025	11	23	17	41	10	11.8	0.1	0.9	25.19	94.8	6.2447	51.9017
2025	11	23	17	51	10	11.8	0.1	0.9	24.53	95.9	6.2447	50.4542
2025	11	23	18	1	10	11.8	0.1	0.9	25.39	94.7	6.2447	52.3152
2025	11	23	18	11	10	11.8	0.1	0.9	24.12	95.7	6.2447	49.6271
2025	11	23	18	21	10	11.8	0.1	0.9	24.17	94.3	6.2447	49.8339
2025	11	23	18	31	10	11.8	0.1	0.9	25.41	95.4	6.2447	52.3153
2025	11	23	18	41	10	11.8	0.1	0.9	24.49	94.9	6.2447	50.4543
2025	11	23	18	51	10	11.8	0.1	0.9	24.82	95.5	6.2447	51.0746
2025	11	23	19	1	10	11.8	0.1	0.9	25.74	96	6.2447	52.9356
2025	11	23	19	11	10	11.8	0.1	0.9	24.26	94	6.2447	50.0407
2025	11	23	19	21	10	11.8	0.1	0.9	25.14	93.4	6.2447	51.9017
2025	11	23	19	31	10	11.8	0.1	0.9	24.23	95.9	6.2447	49.834
2025	11	23	19	41	10	11.8	0.1	0.9	24.93	95.8	6.2447	51.2815
2025	11	23	19	51	10	11.8	0.1	0.9	25.23	93	6.2447	52.1086
2025	11	23	20	1	10	11.8	0.1	0.9	25.15	93.6	6.2447	51.9018
2025	11	23	20	11	10	11.8	0.1	0.9	25.21	95.2	6.2447	51.9019
2025	11	23	20	21	10	11.8	0.1	0.9	24.23	95.9	6.2447	49.8341
2025	11	23	20	31	10	11.6	0.1	0.9	24.43	95.9	6.2447	50.2477
2025	11	23	20	41	10	11.6	0.1	0.9	25.89	94.9	6.2447	53.3494
2025	11	23	20	51	10	11.6	0.1	0.9	24.29	95	6.2447	50.0409
2025	11	23	21	1	10	11.6	0.1	0.9	24.89	97.2	6.2386	51.0229
2025	11	23	21	11	10	11.6	0.1	0.9	24.56	94	6.2386	50.6097
2025	11	23	21	21	10	11.6	0.1	0.9	24.73	93	6.2386	51.0229
2025	11	23	21	31	10	11.6	0.1	0.9	24.48	94.7	6.2386	50.4032
2025	11	23	21	41	10	11.6	0.1	0.9	25.65	93.6	6.2386	52.8821
2025	11	23	21	51	10	11.6	0.1	0.9	24.27	94.5	6.2386	49.9901
2025	11	23	22	1	10	11.6	0.1	0.9	25.04	93.2	6.2386	51.6427
2025	11	23	22	11	10	11.6	0.1	0.9	24.23	92.8	6.2386	49.9902
2025	11	23	22	21	10	11.6	0.1	0.9	24.67	94.2	6.2386	50.8165
2025	11	23	22	31	10	11.6	0.1	0.9	25.34	93.2	6.2386	52.2625
2025	11	23	22	41	10	11.6	0.1	0.9	24.71	95.3	6.2386	50.8166
2025	11	23	22	51	10	11.6	0.1	0.9	24.71	95.3	6.2386	50.8166
2025	11	23	23	1	10	11.6	0.1	0.9	25.11	95.5	6.2386	51.6429
2025	11	23	23	11	10	11.6	0.1	0.9	25.08	94.6	6.2386	51.6429
2025	11	23	23	21	10	11.6	0.1	0.9	25.31	95.4	6.2386	52.0561
2025	11	23	23	31	10	11.6	0.1	0.9	25.19	94.8	6.2386	51.8495
2025	11	23	23	41	10	11.6	0.1	0.9	24.25	96.4	6.2386	49.7839
2025	11	23	23	51	10	11.6	0.1	0.9	25.19	94.8	6.2386	51.8496

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	24	0	1	10	11.6	0.1	0.9	24.54	96.1	6.2386	50.4036
2025	11	24	0	11	10	11.6	0.1	0.9	25.05	93.7	6.2326	51.5904
2025	11	24	0	21	10	11.6	0.1	0.9	25.17	94.3	6.2326	51.7968
2025	11	24	0	31	10	11.6	0.1	0.9	24.72	95.6	6.2386	50.8169
2025	11	24	0	41	10	11.6	0.1	0.9	25.31	91.6	6.2326	52.2096
2025	11	24	0	51	10	11.6	0.1	0.9	23.79	95.1	6.2326	48.9078
2025	11	24	1	1	10	11.6	0.1	0.9	26.17	94.2	6.2326	53.8606
2025	11	24	1	11	10	11.6	0.1	0.9	24.51	95.4	6.2326	50.3524
2025	11	24	1	21	10	11.6	0.1	0.9	25.2	95	6.2326	51.797
2025	11	24	1	31	10	11.6	0.1	0.9	25.03	95.7	6.2326	51.3843
2025	11	24	1	41	10	11.6	0.1	0.9	25.09	94.8	6.2326	51.5907
2025	11	24	1	51	10	11.6	0.1	0.9	24.57	96.8	6.2326	50.3525
2025	11	24	2	1	10	11.6	0.1	0.9	25.02	95.5	6.2326	51.3843
2025	11	24	2	11	10	11.6	0.1	0.9	26.11	95.3	6.2326	53.6544
2025	11	24	2	21	10	11.6	0.1	0.9	25.28	94.5	6.2326	52.0035
2025	11	24	2	31	10	11.6	0.1	0.9	25.2	95	6.2326	51.7971
2025	11	24	2	41	10	11.6	0.1	0.9	25.89	94.7	6.2326	53.2417
2025	11	24	2	51	10	11.6	0.1	0.9	25.65	93.6	6.2326	52.829
2025	11	24	3	1	10	11.6	0.1	0.9	25.3	95.2	6.2326	52.0036
2025	11	24	3	11	10	11.6	0.1	0.9	25.55	96.3	6.2326	52.4163
2025	11	24	3	21	10	11.6	0.1	0.9	24	95.3	6.2326	49.3209
2025	11	24	3	31	10	11.6	0.1	0.9	25.15	93.6	6.2326	51.7973
2025	11	24	3	41	10	11.6	0.1	0.9	25.21	95.2	6.2326	51.7973
2025	11	24	3	51	10	11.6	0.1	0.9	25.4	95.2	6.2326	52.21
2025	11	24	4	1	10	11.6	0.1	0.9	25.53	92.7	6.2326	52.6228
2025	11	24	4	11	10	11.6	0.1	0.9	25.38	96.8	6.2326	52.0037
2025	11	24	4	21	10	11.6	0.1	0.9	24.55	93.5	6.2326	50.5592
2025	11	24	4	31	10	11.6	0.1	0.9	24.37	94.5	6.2326	50.1465
2025	11	24	4	41	10	11.6	0.1	0.9	25.16	96.4	6.2326	51.5911
2025	11	24	4	51	10	11.6	0.1	0.9	24.68	94.6	6.2326	50.7656
2025	11	24	5	1	10	11.6	0.1	0.9	25.45	93.6	6.2265	52.363
2025	11	24	5	11	10	11.6	0.1	0.9	24.85	96.2	6.2265	50.92
2025	11	24	5	21	10	11.6	0.1	0.9	24.86	96.5	6.2265	50.92
2025	11	24	5	31	10	11.6	0.1	0.9	23.49	95.1	6.2265	48.24
2025	11	24	5	41	10	11.6	0.1	0.9	24.65	93.5	6.2265	50.7139
2025	11	24	5	51	10	11.6	0.1	0.9	23.64	93.4	6.2265	48.6523
2025	11	24	6	1	10	11.6	0.1	0.9	25	95	6.2265	51.3324
2025	11	24	6	11	10	11.6	0.1	0.9	24.68	94.6	6.2265	50.7139
2025	11	24	6	21	10	11.4	0.1	0.9	24.52	95.6	6.2265	50.3016
2025	11	24	6	31	10	11.4	0.1	0.9	25.36	96.3	6.2265	51.9509
2025	11	24	6	41	10	11.4	0.1	0.9	25.32	95.7	6.2265	51.9509
2025	11	24	6	51	10	11.4	0.1	0.9	24.67	94.2	6.2265	50.714
2025	11	24	7	1	10	11.4	0.1	0.9	25	95	6.2265	51.3324
2025	11	24	7	11	10	11.4	0.1	0.9	25.84	93.3	6.2265	53.1878
2025	11	24	7	21	10	11.4	0.1	0.9	25.23	92.7	6.2265	51.9509
2025	11	24	7	31	10	11.4	0.1	0.9	25.81	91.8	6.2265	53.1879
2025	11	24	7	41	10	11.4	0.1	0.9	24.6	95.1	6.2265	50.5079
2025	11	24	7	51	10	11.4	0.1	0.9	23.29	95.2	6.2265	47.8279

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	24	8	1	10	11.4	0.1	0.9	24.85	96.2	6.2265	50.9202
2025	11	24	8	11	10	11.4	0.1	0.9	24.8	95.1	6.2265	50.9202
2025	11	24	8	21	10	11.4	0.1	0.9	24.96	93.9	6.2265	51.3325
2025	11	24	8	31	10	11.8	0.1	0.9	24.82	95.5	6.2265	50.9202
2025	11	24	8	41	10	11.8	0.1	0.9	25.42	95.6	6.2265	52.1571
2025	11	24	8	51	10	12	0.1	0.9	24.46	94	6.2265	50.3017
2025	11	24	9	1	10	12.2	0.1	0.9	24.51	91.9	6.2265	50.5079
2025	11	24	9	11	10	12.2	0.1	0.9	25.4	95.2	6.2265	52.1571
2025	11	24	9	21	10	12.2	0.1	0.9	23.88	94.8	6.2204	49.0147
2025	11	24	9	31	10	12.4	0.1	0.9	24.5	95.2	6.2265	50.3017
2025	11	24	9	41	10	12.4	0.1	0.9	25.47	94.3	6.2265	52.3632
2025	11	24	9	51	10	12.4	0.1	0.9	23.68	94.8	6.2204	48.6027
2025	11	24	10	1	10	12.4	0.1	0.9	24.97	94.4	6.2265	51.3324
2025	11	24	10	11	10	12.4	0.1	0.9	24.5	97.3	6.2265	50.0954
2025	11	24	10	21	10	12.4	0.1	0.9	24.58	97	6.2265	50.3016
2025	11	24	10	31	10	12.4	0.1	0.9	24.39	97.1	6.2265	49.8892
2025	11	24	10	41	10	12.4	0.1	0.9	25.08	94.6	6.2265	51.5384
2025	11	24	10	51	10	12.4	0.1	0.9	25.04	93.4	6.2265	51.5384
2025	11	24	11	1	10	12.6	0.1	0.9	25.21	95.2	6.2265	51.7445
2025	11	24	11	11	10	12.6	0.1	0.9	24.31	91.9	6.2265	50.0952
2025	11	24	11	21	10	12.6	0.1	0.9	24.47	94.5	6.2265	50.3013
2025	11	24	11	31	10	12.8	0.1	0.9	22.77	94.5	6.2265	46.7967
2025	11	24	11	41	10	12.8	0.1	0.9	24.32	92.6	6.2265	50.0951
2025	11	24	11	51	10	12.8	0.1	0.9	23.64	93.4	6.2265	48.652
2025	11	24	12	1	10	12.8	0.1	0.9	25.25	93.6	6.2265	51.9504
2025	11	24	12	11	10	12.8	0.1	0.9	23.83	92.6	6.2265	49.0642
2025	11	24	12	21	10	12.8	0.1	0.9	23.65	93.9	6.2265	48.6519
2025	11	24	12	31	10	12.8	0.1	0.9	24.14	93.3	6.2265	49.6826
2025	11	24	12	41	10	12.8	0.1	0.9	24.58	94.7	6.2265	50.5071
2025	11	24	12	51	10	12.8	0.1	0.9	24.04	93.3	6.2326	49.5269
2025	11	24	13	1	10	12.8	0.1	0.9	24.36	94	6.2326	50.1459
2025	11	24	13	11	10	12.6	0.1	0.9	24.84	96	6.2326	50.9713
2025	11	24	13	21	10	13	0.1	0.9	25.24	93.4	6.2326	52.0031
2025	11	24	13	31	10	12.6	0.1	0.9	25.29	94.8	6.2326	52.003
2025	11	24	13	41	10	12.6	0.1	0.9	25.33	95.9	6.2326	52.003
2025	11	24	13	51	10	12.6	0.1	0.9	24.76	96.5	6.2326	50.7648
2025	11	24	14	1	10	12.6	0.1	0.9	25.16	93.9	6.2326	51.7965
2025	11	24	14	11	10	12.6	0.1	0.9	24.62	95.6	6.2326	50.5583
2025	11	24	14	21	10	12.8	0.1	0.9	23.95	93.6	6.2326	49.3201
2025	11	24	14	31	10	12.8	0.1	0.9	24.75	93.5	6.2326	50.971
2025	11	24	14	41	10	12.6	0.1	0.9	24.47	94.2	6.2386	50.4033
2025	11	24	14	51	10	12.8	0.1	0.9	24.71	91.9	6.2386	51.023
2025	11	24	15	1	10	13	0.1	0.9	25.79	94.7	6.2386	53.0886
2025	11	24	15	11	10	13	0.1	0.9	24.84	93.2	6.2386	51.2295
2025	11	24	15	21	10	13	0.1	0.9	25.17	94.3	6.2386	51.8492
2025	11	24	15	31	10	13	0.1	0.9	23.9	95.3	6.2386	49.1637
2025	11	24	15	41	10	13.2	0.1	0.9	26.19	94.8	6.2386	53.9148
2025	11	24	15	51	10	13.2	0.1	0.9	25.01	95.3	6.2386	51.436

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	24	16	1	10	13.2	0.1	0.9	25.42	95.6	6.2386	52.2623
2025	11	24	16	11	10	13.2	0.1	0.9	24.87	96.7	6.2386	51.0228
2025	11	24	16	21	10	12.4	0.1	0.9	24.95	93.7	6.2386	51.436
2025	11	24	16	31	10	12.2	0.1	0.9	24.51	97.5	6.2386	50.1965
2025	11	24	16	41	10	12.2	0.1	0.9	25.4	95	6.2386	52.2622
2025	11	24	16	51	10	12.2	0.1	0.9	24.65	93.5	6.2386	50.8162
2025	11	24	17	1	10	12	0.1	0.9	24.33	93.1	6.2386	50.1965
2025	11	24	17	11	10	12	0.1	0.9	24.82	92.5	6.2386	51.2293
2025	11	24	17	21	10	12	0.1	0.9	23.91	95.5	6.2386	49.1636
2025	11	24	17	31	10	12	0.1	0.9	24.51	95.4	6.2386	50.4031
2025	11	24	17	41	10	12	0.1	0.9	24.74	93.2	6.2386	51.0228
2025	11	24	17	51	10	12	0.1	0.9	24.85	96.2	6.2386	51.0228
2025	11	24	18	1	10	12	0.1	0.9	24.43	93	6.2386	50.4031
2025	11	24	18	11	10	12	0.1	0.9	24.69	94.9	6.2386	50.8162
2025	11	24	18	21	10	12	0.1	0.9	24.93	93	6.2386	51.436
2025	11	24	18	31	10	11.8	0.1	0.9	25.84	93.1	6.2386	53.2951
2025	11	24	18	41	10	11.8	0.1	0.9	24.84	96	6.2386	51.0228
2025	11	24	18	51	10	11.8	0.1	0.9	25.66	93.8	6.2386	52.882
2025	11	24	19	1	10	11.8	0.1	0.9	24.8	95.1	6.2386	51.0229
2025	11	24	19	11	10	11.8	0.1	0.9	25.85	93.5	6.2386	53.2952
2025	11	24	19	21	10	11.8	0.1	0.9	23.83	96	6.2386	48.9572
2025	11	24	19	31	10	11.8	0.1	0.9	24.8	95.1	6.2386	51.0229
2025	11	24	19	41	10	11.8	0.1	0.9	24.67	96.8	6.2386	50.6098
2025	11	24	19	51	10	11.8	0.1	0.9	24.44	96.1	6.2386	50.1967
2025	11	24	20	1	10	11.8	0.1	0.9	24.78	94.6	6.2386	51.023
2025	11	24	20	11	10	11.8	0.1	0.9	25.11	95.5	6.2386	51.6428
2025	11	24	20	21	10	11.8	0.1	0.9	25.02	97.6	6.2386	51.2297
2025	11	24	20	31	10	11.8	0.1	0.9	24.45	96.3	6.2386	50.1968
2025	11	24	20	41	10	11.8	0.1	0.9	24.55	93.7	6.2386	50.61
2025	11	24	20	51	10	11.8	0.1	0.9	25.74	96	6.2386	52.8823
2025	11	24	21	1	10	11.8	0.1	0.9	24.65	96.3	6.2386	50.6101
2025	11	24	21	11	10	11.8	0.1	0.9	25.79	94.7	6.2326	53.0348
2025	11	24	21	21	10	11.8	0.1	0.9	24.86	93.9	6.2326	51.1776
2025	11	24	21	31	10	11.8	0.1	0.9	24.82	92.5	6.2386	51.2299
2025	11	24	21	41	10	11.8	0.1	0.9	24.98	94.6	6.2326	51.384
2025	11	24	21	51	10	11.8	0.1	0.9	25.41	91.8	6.2326	52.4159
2025	11	24	22	1	10	11.8	0.1	0.9	24.61	95.4	6.2326	50.5586
2025	11	24	22	11	10	11.8	0.1	0.9	25.39	97	6.2326	52.0032
2025	11	24	22	21	10	11.8	0.1	0.9	24.17	94.3	6.2326	49.7332
2025	11	24	22	31	10	11.8	0.1	0.9	24.63	95.8	6.2326	50.5587
2025	11	24	22	41	10	11.8	0.1	0.9	24.7	95.1	6.2326	50.7651
2025	11	24	22	51	10	11.8	0.1	0.9	24.89	94.8	6.2326	51.1779
2025	11	24	23	1	10	11.8	0.1	0.9	24.17	94.5	6.2326	49.7334
2025	11	24	23	11	10	11.8	0.1	0.9	25.47	96.5	6.2326	52.2097
2025	11	24	23	21	10	11.8	0.1	0.9	25.11	95.3	6.2326	51.5907
2025	11	24	23	31	10	11.8	0.1	0.9	25.16	93.9	6.2326	51.7971
2025	11	24	23	41	10	11.8	0.1	0.9	24.52	95.6	6.2326	50.3526
2025	11	24	23	51	10	11.8	0.1	0.9	23.99	95	6.2326	49.3208

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	25	0	1	10	11.8	0.1	0.9	25.28	94.5	6.2326	52.0035
2025	11	25	0	11	10	11.8	0.1	0.9	25.21	95.5	6.2326	51.7972
2025	11	25	0	21	10	11.8	0.1	0.9	25.17	94.3	6.2326	51.7972
2025	11	25	0	31	10	11.8	0.1	0.9	25.24	96.1	6.2326	51.7972
2025	11	25	0	41	10	11.8	0.1	0.9	23.85	93.8	6.2326	49.1145
2025	11	25	0	51	10	11.8	0.1	0.9	23.91	95.5	6.2326	49.1146
2025	11	25	1	1	10	11.8	0.1	0.9	24.35	93.8	6.2326	50.1464
2025	11	25	1	11	10	11.8	0.1	0.9	25.03	95.7	6.2326	51.3846
2025	11	25	1	21	10	11.8	0.1	0.9	24.47	94.5	6.2326	50.3528
2025	11	25	1	31	10	11.8	0.1	0.9	25.03	92.7	6.2326	51.591
2025	11	25	1	41	10	11.8	0.1	0.9	25	95	6.2326	51.3847
2025	11	25	1	51	10	11.8	0.1	0.9	25.18	94.6	6.2326	51.7974
2025	11	25	2	1	10	11.8	0.1	0.9	24.89	94.8	6.2326	51.1784
2025	11	25	2	11	10	11.8	0.1	0.9	23.88	94.8	6.2265	49.0646
2025	11	25	2	21	10	11.8	0.1	0.9	24.58	94.7	6.2326	50.5593
2025	11	25	2	31	10	11.8	0.1	0.9	24.48	94.7	6.2265	50.3016
2025	11	25	2	41	10	11.8	0.1	0.9	24.67	94.4	6.2265	50.7139
2025	11	25	2	51	10	11.6	0.1	0.9	23.77	94.3	6.2265	48.8586
2025	11	25	3	1	10	11.6	0.1	0.9	24.89	94.8	6.2265	51.1263
2025	11	25	3	11	10	11.6	0.1	0.9	24.69	94.9	6.2265	50.714
2025	11	25	3	21	10	11.6	0.1	0.9	24.88	96.9	6.2265	50.9202
2025	11	25	3	31	10	11.6	0.1	0.9	24.58	94.7	6.2265	50.5079
2025	11	25	3	41	10	11.6	0.1	0.9	24.96	93.9	6.2265	51.3325
2025	11	25	3	51	10	11.6	0.1	0.9	24.3	95.2	6.2265	49.8894
2025	11	25	4	1	10	11.6	0.1	0.9	23.98	94.8	6.2265	49.271
2025	11	25	4	11	10	11.6	0.1	0.9	24.65	96.3	6.2265	50.5079
2025	11	25	4	21	10	11.6	0.1	0.9	23.35	93.9	6.2265	48.0341
2025	11	25	4	31	10	11.6	0.1	0.9	24.64	96.1	6.2265	50.508
2025	11	25	4	41	10	11.6	0.1	0.9	25.04	96	6.2265	51.3326
2025	11	25	4	51	10	11.6	0.1	0.9	24.27	94.5	6.2265	49.8895
2025	11	25	5	1	10	11.6	0.1	0.9	25.49	97	6.2265	52.1572
2025	11	25	5	11	10	11.6	0.1	0.9	24.83	95.8	6.2265	50.9203
2025	11	25	5	21	10	11.6	0.1	0.9	25.91	97.3	6.2265	52.9819
2025	11	25	5	31	10	11.6	0.1	0.9	25.18	96.8	6.2265	51.5388
2025	11	25	5	41	10	11.6	0.1	0.9	24.45	93.8	6.2265	50.3019
2025	11	25	5	51	10	11.6	0.1	0.9	24.62	95.6	6.2265	50.508
2025	11	25	6	1	10	11.6	0.1	0.9	24.39	94.9	6.2265	50.0957
2025	11	25	6	11	10	11.6	0.1	0.9	24.35	93.5	6.2265	50.0958
2025	11	25	6	21	10	11.6	0.1	0.9	25.2	97.3	6.2265	51.5388
2025	11	25	6	31	10	11.6	0.1	0.9	24.7	90.7	6.2265	50.9204
2025	11	25	6	41	10	11.6	0.1	0.9	25.14	93.4	6.2265	51.745
2025	11	25	6	51	10	11.6	0.1	0.9	24.6	95.1	6.2265	50.5081
2025	11	25	7	1	10	11.6	0.1	0.9	25.8	97.1	6.2265	52.7758
2025	11	25	7	11	10	11.6	0.1	0.9	23.8	95.3	6.2265	48.8589
2025	11	25	7	21	10	11.6	0.1	0.9	25.4	95	6.2265	52.1574
2025	11	25	7	31	10	11.6	0.1	0.9	25.27	96.6	6.2265	51.7451
2025	11	25	7	41	10	11.6	0.1	0.9	24.49	94.9	6.2265	50.302
2025	11	25	7	51	10	11.6	0.1	0.9	24.68	94.6	6.2265	50.7143

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	25	8	1	10	11.6	0.1	0.9	24.28	94.7	6.2265	49.8897
2025	11	25	8	11	10	11.6	0.1	0.9	23.89	97.2	6.2265	48.8589
2025	11	25	8	21	10	11.6	0.1	0.9	24.53	95.9	6.2265	50.302
2025	11	25	8	31	10	12	0.1	0.9	25.75	93.6	6.2265	52.982
2025	11	25	8	41	10	12	0.1	0.9	25.05	93.7	6.2265	51.5389
2025	11	25	8	51	10	12.2	0.1	0.9	24.49	94.9	6.2265	50.302
2025	11	25	9	1	10	12.2	0.1	0.9	24.02	95.7	6.2265	49.2712
2025	11	25	9	11	10	12.4	0.1	0.9	23.85	93.8	6.2265	49.065
2025	11	25	9	21	10	12.4	0.1	0.9	23.5	95.4	6.2265	48.2404
2025	11	25	9	31	10	12.4	0.1	0.9	25.17	98.5	6.2265	51.3327
2025	11	25	9	41	10	12.6	0.1	0.9	23.16	94	6.2265	47.6219
2025	11	25	9	51	10	12.6	0.1	0.9	24.22	95.7	6.2265	49.6834
2025	11	25	10	1	10	12.6	0.1	0.9	24.37	94.2	6.2265	50.0957
2025	11	25	10	11	10	12.6	0.1	0.9	24.98	94.6	6.2265	51.3326
2025	11	25	10	21	10	12.8	0.1	0.9	24.03	96	6.2265	49.271
2025	11	25	10	31	10	12.8	0.1	0.9	25.02	95.5	6.2265	51.3325
2025	11	25	10	41	10	12.8	0.1	0.9	25.81	95.3	6.2265	52.9817
2025	11	25	10	51	10	12.8	0.1	0.9	23.73	96	6.2265	48.6524
2025	11	25	11	1	10	12.8	0.1	0.9	24.76	96.5	6.2265	50.7139
2025	11	25	11	11	10	12.8	0.1	0.9	24.11	91.4	6.2265	49.6831
2025	11	25	11	21	10	12.8	0.1	0.9	25.11	95.3	6.2265	51.5385
2025	11	25	11	31	10	12.8	0.1	0.9	24.86	96.5	6.2265	50.92
2025	11	25	11	41	10	12.8	0.1	0.9	24.58	94.7	6.2326	50.5592
2025	11	25	11	51	10	12.8	0.1	0.9	23.68	94.6	6.2326	48.7019
2025	11	25	12	1	10	12.8	0.1	0.9	24.39	94.9	6.2326	50.1464
2025	11	25	12	11	10	12.8	0.1	0.9	24.96	93.9	6.2326	51.3845
2025	11	25	12	21	10	12.8	0.1	0.9	24.07	94.3	6.2326	49.5272
2025	11	25	12	31	10	12.8	0.1	0.9	23.75	93.9	6.2326	48.9081
2025	11	25	12	41	10	12.8	0.1	0.9	24.93	92.8	6.2326	51.3844
2025	11	25	12	51	10	12.8	0.1	0.9	24.58	97	6.2326	50.3525
2025	11	25	13	1	10	12.8	0.1	0.9	24.01	95.5	6.2326	49.3206
2025	11	25	13	11	10	12.8	0.1	0.9	23.78	97	6.2386	48.7512
2025	11	25	13	21	10	12.8	0.1	0.9	25.39	94.7	6.2386	52.2629
2025	11	25	13	31	10	12.8	0.1	0.9	24.14	98.1	6.2386	49.3709
2025	11	25	13	41	10	12.8	0.1	0.9	25.58	94.5	6.2386	52.676
2025	11	25	13	51	10	13	0.1	0.9	25.82	92.4	6.2386	53.2957
2025	11	25	14	1	10	13	0.1	0.9	24.56	96.5	6.2386	50.4036
2025	11	25	14	11	10	12.8	0.1	0.9	24.06	96.7	6.2447	49.421
2025	11	25	14	21	10	12.8	0.1	0.9	24.51	95.4	6.2447	50.4549
2025	11	25	14	31	10	12.8	0.1	0.9	24.28	94.7	6.2447	50.0413
2025	11	25	14	41	10	12.8	0.1	0.9	25.17	94.3	6.2447	51.9023
2025	11	25	14	51	10	12.8	0.1	0.9	24.65	93.7	6.2447	50.8684
2025	11	25	15	1	10	12.8	0.1	0.9	24.15	93.8	6.2447	49.8345
2025	11	25	15	11	10	12.6	0.1	0.9	25.21	95.5	6.2447	51.9023
2025	11	25	15	21	10	12.6	0.1	0.9	25.3	95.2	6.2447	52.109
2025	11	25	15	31	10	12.6	0.1	0.9	24.82	92.1	6.2447	51.2819
2025	11	25	15	41	10	12.6	0.1	0.9	24.69	94.9	6.2508	50.9201
2025	11	25	15	51	10	12.6	0.1	0.9	24.76	96.5	6.2508	50.9201

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	25	16	1	10	12.6	0.1	0.9	23.48	94.6	6.2508	48.4362
2025	11	25	16	11	10	12.6	0.1	0.9	23.56	94.1	6.2508	48.6432
2025	11	25	16	21	10	12.4	0.1	0.9	25.04	96	6.2508	51.5411
2025	11	25	16	31	10	12.4	0.1	0.9	25.86	93.8	6.2508	53.404
2025	11	25	16	41	10	12.4	0.1	0.9	24.99	94.8	6.2508	51.541
2025	11	25	16	51	10	12.4	0.1	0.9	25.01	95.3	6.2508	51.541
2025	11	25	17	1	10	12.2	0.1	0.9	24.57	96.8	6.2569	50.5575
2025	11	25	17	11	10	12.2	0.1	0.9	24.21	95.5	6.2569	49.9358
2025	11	25	17	21	10	12	0.1	0.9	24.56	96.5	6.2569	50.5575
2025	11	25	17	31	10	12	0.1	0.9	25.59	94.7	6.2569	52.8367
2025	11	25	17	41	10	12	0.1	0.9	23.65	93.9	6.2569	48.8998
2025	11	25	17	51	10	12	0.1	0.9	25.69	96.9	6.2569	52.8367
2025	11	25	18	1	10	12	0.1	0.9	24.98	96.9	6.263	51.4385
2025	11	25	18	11	10	12	0.1	0.9	25.06	93.9	6.263	51.8533
2025	11	25	18	21	10	12	0.1	0.9	24.73	93	6.2691	51.2831
2025	11	25	18	31	10	12	0.1	0.9	25.57	98.3	6.2752	52.5822
2025	11	25	18	41	10	12	0.1	0.9	25.79	94.7	6.2813	53.4677
2025	11	25	18	51	10	12	0.1	0.9	23.95	93.8	6.2813	49.7229
2025	11	25	19	1	10	12	0.1	0.9	25.15	93.6	6.2813	52.2194
2025	11	25	19	11	10	12	0.1	0.9	25.17	96.6	6.2874	52.0641
2025	11	25	19	21	10	12	0.1	0.9	25.55	96.3	6.2874	52.8971
2025	11	25	19	31	10	12	0.1	0.9	26.14	93.1	6.2874	54.3549
2025	11	25	19	41	10	12	0.1	0.9	25.54	97.9	6.2874	52.6889
2025	11	25	19	51	10	12	0.1	0.9	25.39	94.7	6.2874	52.6889
2025	11	25	20	1	10	12	0.1	0.9	24.42	95.6	6.2874	50.6064
2025	11	25	20	11	10	12	0.1	0.9	24.86	93.9	6.2874	51.6477
2025	11	25	20	21	10	12	0.1	0.9	25.28	94.5	6.2935	52.5339
2025	11	25	20	31	10	12	0.1	0.9	25.48	94.5	6.2935	52.9508
2025	11	25	20	41	10	12	0.1	0.9	24.23	95.9	6.2935	50.2408
2025	11	25	20	51	10	12	0.1	0.9	25.47	96.5	6.2935	52.7424
2025	11	25	21	1	10	12	0.1	0.9	24.95	93.7	6.2935	51.9086
2025	11	25	21	11	10	12	0.1	0.9	25.39	97	6.2935	52.534
2025	11	25	21	21	10	12	0.1	0.9	24.57	96.8	6.2935	50.8663
2025	11	25	21	31	10	12	0.1	0.9	26.27	94.1	6.2935	54.6188
2025	11	25	21	41	10	12	0.1	0.9	25.28	96.8	6.2935	52.3256
2025	11	25	21	51	10	12	0.1	0.9	26.05	93.5	6.2935	54.2019
2025	11	25	22	1	10	11.8	0.1	0.9	25.13	92.7	6.2935	52.3257
2025	11	25	22	11	10	11.8	0.1	0.9	26.11	95.3	6.2935	54.2019
2025	11	25	22	21	10	11.8	0.1	0.9	26.36	93.9	6.2935	54.8274
2025	11	25	22	31	10	11.8	0.1	0.9	24.91	95.3	6.2935	51.7004
2025	11	25	22	41	10	11.8	0.1	0.9	25.67	94.2	6.2935	53.3681
2025	11	25	22	51	10	11.8	0.1	0.9	25.4	95.2	6.2935	52.7428
2025	11	25	23	1	10	11.8	0.1	0.9	24.85	93.5	6.2935	51.7004
2025	11	25	23	11	10	11.8	0.1	0.9	24.67	96.8	6.2935	51.0751
2025	11	25	23	21	10	11.8	0.1	0.9	25.41	95.4	6.2935	52.7428
2025	11	25	23	31	10	11.8	0.1	0.9	25.7	95.1	6.2935	53.3683
2025	11	25	23	41	10	11.8	0.1	0.9	25.73	95.8	6.2935	53.3683
2025	11	25	23	51	10	11.8	0.1	0.9	24.73	95.8	6.2935	51.2836

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	26	0	1	10	11.8	0.1	0.9	24.42	95.6	6.2935	50.6583
2025	11	26	0	11	10	11.8	0.1	0.9	24.84	96	6.2935	51.4922
2025	11	26	0	21	10	11.8	0.1	0.9	25.63	95.8	6.2935	53.16
2025	11	26	0	31	10	11.8	0.1	0.9	25.87	94.2	6.2935	53.7854
2025	11	26	0	41	10	11.8	0.1	0.9	25.4	97.2	6.2935	52.5346
2025	11	26	0	51	10	11.8	0.1	0.9	25.46	93.8	6.2935	52.9516
2025	11	26	1	1	10	11.8	0.1	0.9	24.59	94.9	6.2996	51.127
2025	11	26	1	11	10	11.8	0.1	0.9	23.75	96.5	6.2935	49.1991
2025	11	26	1	21	10	11.8	0.1	0.9	25.8	97.1	6.2996	53.4225
2025	11	26	1	31	10	11.8	0.1	0.9	24.91	95.3	6.2935	51.7008
2025	11	26	1	41	10	11.8	0.1	0.9	25.21	95.2	6.2935	52.3263
2025	11	26	1	51	10	11.8	0.1	0.9	25.48	96.8	6.2935	52.7432
2025	11	26	2	1	10	11.8	0.1	0.9	25.8	95.1	6.2935	53.5771
2025	11	26	2	11	10	11.8	0.1	0.9	25.62	95.6	6.2996	53.2139
2025	11	26	2	21	10	11.8	0.1	0.9	25.45	93.6	6.2996	53.0053
2025	11	26	2	31	10	11.8	0.1	0.9	24.82	95.5	6.2935	51.4925
2025	11	26	2	41	10	11.8	0.1	0.9	24.28	94.7	6.2996	50.5011
2025	11	26	2	51	10	11.8	0.1	0.9	25.1	95	6.2996	52.1706
2025	11	26	3	1	10	11.8	0.1	0.9	25.76	94	6.2996	53.6314
2025	11	26	3	11	10	11.8	0.1	0.9	23.51	91.9	6.2996	49.0404
2025	11	26	3	21	10	11.8	0.1	0.9	25.74	93.1	6.2996	53.6314
2025	11	26	3	31	10	11.8	0.1	0.9	25.1	97.3	6.2996	51.962
2025	11	26	3	41	10	11.8	0.1	0.9	24.62	95.6	6.2996	51.1273
2025	11	26	3	51	10	11.8	0.1	0.9	25.39	94.7	6.2935	52.7435
2025	11	26	4	1	10	11.8	0.1	0.9	25.28	94.5	6.2996	52.5881
2025	11	26	4	11	10	11.8	0.1	0.9	24.72	95.6	6.2996	51.336
2025	11	26	4	21	10	11.8	0.1	0.9	24.85	96.2	6.2996	51.5447
2025	11	26	4	31	10	11.8	0.1	0.9	24.55	93.7	6.2996	51.1273
2025	11	26	4	41	10	11.8	0.1	0.9	26.21	91.7	6.2996	54.675
2025	11	26	4	51	10	11.8	0.1	0.9	25.79	96.9	6.2996	53.4229
2025	11	26	5	1	10	11.8	0.1	0.9	25.39	94.7	6.2996	52.7968
2025	11	26	5	11	10	11.8	0.1	0.9	25.18	94.6	6.2996	52.3795
2025	11	26	5	21	10	11.8	0.1	0.9	24.69	94.9	6.2996	51.3361
2025	11	26	5	31	10	11.8	0.1	0.9	24.99	94.8	6.2996	51.9621
2025	11	26	5	41	10	11.8	0.1	0.9	25.39	97	6.2996	52.5882
2025	11	26	5	51	10	11.8	0.1	0.9	25.3	95.2	6.2996	52.5882
2025	11	26	6	1	10	11.8	0.1	0.9	25.42	95.6	6.2935	52.7436
2025	11	26	6	11	10	11.8	0.1	0.9	26.25	93.5	6.2996	54.6751
2025	11	26	6	21	10	11.8	0.1	0.9	24.95	93.7	6.2996	51.9622
2025	11	26	6	31	10	11.8	0.1	0.9	24.05	93.8	6.2996	50.084
2025	11	26	6	41	10	11.8	0.1	0.9	25.24	93.2	6.2996	52.5882
2025	11	26	6	51	10	11.8	0.1	0.9	25.29	97	6.2996	52.3796
2025	11	26	7	1	10	11.8	0.1	0.9	24.75	93.7	6.2996	51.5448
2025	11	26	7	11	10	11.8	0.1	0.9	25.74	93.3	6.2935	53.5775
2025	11	26	7	21	10	11.8	0.1	0.9	25.31	95.4	6.2996	52.5883
2025	11	26	7	31	10	11.8	0.1	0.9	25.3	95.2	6.2996	52.5883
2025	11	26	7	41	10	11.8	0.1	0.9	24.48	94.7	6.2996	50.9188
2025	11	26	7	51	10	11.8	0.1	0.9	24.48	94.7	6.2996	50.9188

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	26	8	1	10	11.8	0.1	0.9	25.3	95.2	6.2996	52.5883
2025	11	26	8	11	10	11.8	0.1	0.9	24.39	94.9	6.2996	50.7101
2025	11	26	8	21	10	11.8	0.1	0.9	25.33	95.9	6.2935	52.5352
2025	11	26	8	31	10	12	0.1	0.9	25.2	97.3	6.2996	52.1709
2025	11	26	8	41	10	12.2	0.1	0.9	25.81	95.3	6.2935	53.5776
2025	11	26	8	51	10	12.2	0.1	0.9	26.41	95.2	6.2996	54.8838
2025	11	26	9	1	10	12.4	0.1	0.9	25.8	97.1	6.2996	53.423
2025	11	26	9	11	10	12.6	0.1	0.9	25.36	96.3	6.2996	52.5883
2025	11	26	9	21	10	12.6	0.1	0.9	25.18	96.8	6.2996	52.1709
2025	11	26	9	31	10	12.8	0.1	0.9	26.5	95	6.2996	55.0924
2025	11	26	9	41	10	12.8	0.1	0.9	24.09	95	6.2996	50.084
2025	11	26	9	51	10	12.8	0.1	0.9	24.57	94.4	6.2996	51.1274
2025	11	26	10	1	10	13	0.1	0.9	25.74	97.8	6.2996	53.2142
2025	11	26	10	11	10	12.8	0.1	0.9	26.08	94.4	6.2996	54.2576
2025	11	26	10	21	10	13.4	0.1	0.9	25.16	96.4	6.2996	52.1707
2025	11	26	10	31	10	13.4	0.1	0.9	24.61	97.5	6.2996	50.9186
2025	11	26	10	41	10	13.6	0.1	0.9	24.12	95.7	6.2996	50.0838
2025	11	26	10	51	10	13.4	0.1	0.9	23.98	96.9	6.2996	49.6664
2025	11	26	11	1	10	13.4	0.1	0.9	25.48	94.5	6.2996	53.0053
2025	11	26	11	11	10	13.4	0.1	0.9	24.96	96.4	6.2996	51.7532
2025	11	26	11	21	10	13.4	0.1	0.9	25.41	95.4	6.2996	52.7965
2025	11	26	11	31	10	13.4	0.1	0.9	26.68	94.5	6.2996	55.5093
2025	11	26	11	41	10	13.4	0.1	0.9	25.05	96.2	6.2996	51.9617
2025	11	26	11	51	10	13.4	0.1	0.9	26.06	93.7	6.2996	54.2571
2025	11	26	12	1	10	13.2	0.1	0.9	24.82	95.5	6.2996	51.5442
2025	11	26	12	11	10	13.4	0.1	0.9	24.86	96.5	6.2996	51.5442
2025	11	26	12	21	10	13.4	0.1	0.9	25.34	96.1	6.3057	52.6406
2025	11	26	12	31	10	13.2	0.1	0.9	25.61	95.4	6.3057	53.2672
2025	11	26	12	41	10	13.2	0.1	0.9	26.33	92.6	6.3057	54.9383
2025	11	26	12	51	10	13.2	0.1	0.9	24.61	97.5	6.3057	50.9693
2025	11	26	13	1	10	13.2	0.1	0.9	24.08	96.9	6.3057	49.9248
2025	11	26	13	11	10	13.2	0.1	0.9	25.6	95.2	6.3057	53.267
2025	11	26	13	21	10	13.4	0.1	0.9	25.02	95.5	6.3057	52.0136
2025	11	26	13	31	10	13.4	0.1	0.9	26.04	96	6.3057	54.1025
2025	11	26	13	41	10	13.4	0.1	0.9	25	95	6.3057	52.0136
2025	11	26	13	51	10	13.4	0.1	0.9	25.71	91.8	6.3057	53.6846
2025	11	26	14	1	10	13.4	0.1	0.9	25.59	94.7	6.3057	53.2668
2025	11	26	14	11	10	13.4	0.1	0.9	25.39	94.7	6.3057	52.849
2025	11	26	14	21	10	13.4	0.1	0.9	25.85	93.5	6.3057	53.8934
2025	11	26	14	31	10	13.4	0.1	0.9	25.36	93.8	6.3057	52.8489
2025	11	26	14	41	10	13	0.1	0.9	25.17	94.3	6.3057	52.4311
2025	11	26	14	51	10	13.2	0.1	0.9	24.73	92.8	6.3057	51.5955
2025	11	26	15	1	10	13.4	0.1	0.9	24.64	93.3	6.3118	51.4384
2025	11	26	15	11	10	13.2	0.1	0.9	25.19	94.8	6.3118	52.4839
2025	11	26	15	21	10	13.2	0.1	0.9	25.05	93.7	6.3057	52.2221
2025	11	26	15	31	10	13.2	0.1	0.9	25.47	96.5	6.3118	52.9021
2025	11	26	15	41	10	13.2	0.1	0.9	24.77	94.2	6.3118	51.6475
2025	11	26	15	51	10	13	0.1	0.9	24.64	93.3	6.3118	51.4383

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	26	16	1	10	12.8	0.1	0.9	25.63	95.8	6.3118	53.3202
2025	11	26	16	11	10	13	0.1	0.9	25.07	94.3	6.3118	52.2747
2025	11	26	16	21	10	13	0.1	0.9	25.51	95.4	6.3118	53.1111
2025	11	26	16	31	10	13.2	0.1	0.9	24.27	94.5	6.3118	50.6019
2025	11	26	16	41	10	13	0.1	0.9	23.53	96.1	6.3118	48.9291
2025	11	26	16	51	10	12.8	0.1	0.9	24.69	94.9	6.3118	51.4383
2025	11	26	17	1	10	11.8	0.1	0.9	25.54	96.1	6.3118	53.1111
2025	11	26	17	11	10	11.6	0.1	0.9	25.58	96.7	6.3118	53.1111
2025	11	26	17	21	10	12.2	0.1	0.9	25.29	94.8	6.3118	52.6929
2025	11	26	17	31	10	12.2	0.1	0.9	24.75	93.7	6.3118	51.6474
2025	11	26	17	41	10	12.2	0.1	0.9	24.33	95.9	6.3118	50.6019
2025	11	26	17	51	10	12.2	0.1	0.9	25.95	93.5	6.3118	54.1566
2025	11	26	18	1	10	12.2	0.1	0.9	25.59	94.7	6.3118	53.3202
2025	11	26	18	11	10	12.2	0.1	0.9	25.13	95.9	6.3118	52.2747
2025	11	26	18	21	10	12.2	0.1	0.9	24.81	91.8	6.3118	51.8565
2025	11	26	18	31	10	12	0.1	0.9	25.19	94.8	6.3118	52.4838
2025	11	26	18	41	10	12	0.1	0.9	26.02	95.5	6.3118	54.1566
2025	11	26	18	51	10	12	0.1	0.9	25.59	97	6.3118	53.1111
2025	11	26	19	1	10	12	0.1	0.9	25.13	95.9	6.3118	52.2748
2025	11	26	19	11	10	12	0.1	0.9	25.76	94	6.3118	53.7385
2025	11	26	19	21	10	12	0.1	0.9	25.11	95.3	6.3118	52.2748
2025	11	26	19	31	10	12	0.1	0.9	25.17	96.6	6.3118	52.2748
2025	11	26	19	41	10	12	0.1	0.9	25.34	93.2	6.3118	52.9022
2025	11	26	19	51	10	12	0.1	0.9	25.22	95.7	6.3118	52.484
2025	11	26	20	1	10	12	0.1	0.9	24.53	92.8	6.3118	51.2294
2025	11	26	20	11	10	12	0.1	0.9	25.81	95.3	6.3118	53.7387
2025	11	26	20	21	10	12	0.1	0.9	24.98	94.6	6.3057	52.0134
2025	11	26	20	31	10	12	0.1	0.9	26.18	94.4	6.3118	54.5751
2025	11	26	20	41	10	12	0.1	0.9	25.5	95	6.3118	53.1114
2025	11	26	20	51	10	12	0.1	0.9	25.34	93.2	6.3118	52.9024
2025	11	26	21	1	10	12	0.1	0.9	24.61	95.4	6.3118	51.2296
2025	11	26	21	11	10	12	0.1	0.9	25.14	93.2	6.3118	52.4842
2025	11	26	21	21	10	12	0.1	0.9	25.92	92.4	6.3118	54.1571
2025	11	26	21	31	10	12	0.1	0.9	26.38	94.3	6.3057	54.9381
2025	11	26	21	41	10	12	0.1	0.9	24.32	92.1	6.3057	50.7603
2025	11	26	21	51	10	12	0.1	0.9	26.18	94.4	6.3118	54.5754
2025	11	26	22	1	10	12	0.1	0.9	25.89	94.7	6.3057	53.8937
2025	11	26	22	11	10	12	0.1	0.9	25.13	95.9	6.3057	52.2226
2025	11	26	22	21	10	12	0.1	0.9	25.28	94.5	6.3057	52.6404
2025	11	26	22	31	10	12	0.1	0.9	25	95	6.3057	52.0138
2025	11	26	22	41	10	12	0.1	0.9	25.23	93	6.3057	52.6405
2025	11	26	22	51	10	12	0.1	0.9	25.63	92.7	6.3057	53.4761
2025	11	26	23	1	10	12	0.1	0.9	26.49	96.9	6.3057	54.9384
2025	11	26	23	11	10	12	0.1	0.9	23.91	95.5	6.3057	49.7161
2025	11	26	23	21	10	12	0.1	0.9	25.99	94.9	6.3057	54.1028
2025	11	26	23	31	10	12	0.1	0.9	24.37	94.2	6.3057	50.7606
2025	11	26	23	41	10	12	0.1	0.9	25.19	94.8	6.3057	52.4318
2025	11	26	23	51	10	12	0.1	0.9	25.11	95.5	6.3057	52.2229

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	27	0	1	10	12	0.1	0.9	24.85	93.7	6.3057	51.8051
2025	11	27	0	11	10	12	0.1	0.9	25.55	96.3	6.3057	53.0585
2025	11	27	0	21	10	12	0.1	0.9	25.09	94.8	6.3057	52.223
2025	11	27	0	31	10	12	0.1	0.9	25.74	93.1	6.3057	53.6852
2025	11	27	0	41	10	12	0.1	0.9	25.5	95	6.3057	53.0586
2025	11	27	0	51	10	12	0.1	0.9	25.09	94.8	6.3057	52.223
2025	11	27	1	1	10	12	0.1	0.9	26.39	94.8	6.3057	54.9387
2025	11	27	1	11	10	11.8	0.1	0.9	25.34	96.1	6.3057	52.6409
2025	11	27	1	21	10	11.8	0.1	0.9	26.57	94.1	6.3057	55.3565
2025	11	27	1	31	10	11.8	0.1	0.9	25.82	95.6	6.2996	53.6312
2025	11	27	1	41	10	11.8	0.1	0.9	25.11	95.5	6.3057	52.2231
2025	11	27	1	51	10	11.8	0.1	0.9	25.92	95.5	6.3057	53.8943
2025	11	27	2	1	10	11.8	0.1	0.9	24.88	94.6	6.2996	51.7532
2025	11	27	2	11	10	11.8	0.1	0.9	24.5	95.2	6.2996	50.9185
2025	11	27	2	21	10	11.8	0.1	0.9	25.16	94.1	6.2996	52.3793
2025	11	27	2	31	10	11.8	0.1	0.9	24.18	94.7	6.2996	50.2924
2025	11	27	2	41	10	11.8	0.1	0.9	25.47	94.3	6.3057	53.0588
2025	11	27	2	51	10	11.8	0.1	0.9	24.96	96.4	6.2996	51.7533
2025	11	27	3	1	10	11.8	0.1	0.9	24.96	94.1	6.2996	51.962
2025	11	27	3	11	10	11.8	0.1	0.9	25.33	92.9	6.2996	52.7967
2025	11	27	3	21	10	11.8	0.1	0.9	25.12	95.7	6.2996	52.1707
2025	11	27	3	31	10	11.8	0.1	0.9	25.56	93.8	6.2996	53.2141
2025	11	27	3	41	10	11.8	0.1	0.9	24.85	93.7	6.2996	51.7534
2025	11	27	3	51	10	11.8	0.1	0.9	25.26	96.4	6.2996	52.3794
2025	11	27	4	1	10	11.8	0.1	0.9	25.33	92.9	6.2996	52.7968
2025	11	27	4	11	10	11.8	0.1	0.9	27.03	95.5	6.2996	56.1357
2025	11	27	4	21	10	11.8	0.1	0.9	25.51	95.4	6.2996	53.0055
2025	11	27	4	31	10	11.8	0.1	0.9	26.15	96.1	6.2996	54.2576
2025	11	27	4	41	10	11.8	0.1	0.9	24.74	96	6.2996	51.3361
2025	11	27	4	51	10	11.8	0.1	0.9	25.45	96.3	6.2996	52.7969
2025	11	27	5	1	10	11.8	0.1	0.9	26.03	95.7	6.2996	54.049
2025	11	27	5	11	10	11.8	0.1	0.9	25.02	92.5	6.2996	52.1708
2025	11	27	5	21	10	11.8	0.1	0.9	23.75	96.5	6.2996	49.2493
2025	11	27	5	31	10	11.8	0.1	0.9	26.48	96.7	6.2996	54.8837
2025	11	27	5	41	10	11.8	0.1	0.9	25.03	97.8	6.2996	51.7535
2025	11	27	5	51	10	11.8	0.1	0.9	24.94	96	6.2996	51.7535
2025	11	27	6	1	10	11.8	0.1	0.9	24.65	96.3	6.2935	51.0759
2025	11	27	6	11	10	11.8	0.1	0.9	25.4	97.2	6.2935	52.5352
2025	11	27	6	21	10	11.8	0.1	0.9	24.9	95.1	6.2935	51.7013
2025	11	27	6	31	10	11.8	0.1	0.9	24.22	95.7	6.2935	50.242
2025	11	27	6	41	10	11.8	0.1	0.9	25.46	94.1	6.2935	52.9522
2025	11	27	6	51	10	11.8	0.1	0.9	25.21	95.2	6.2935	52.3267
2025	11	27	7	1	10	11.8	0.1	0.9	25.01	95.3	6.2935	51.9098
2025	11	27	7	11	10	11.8	0.1	0.9	24.87	94.4	6.2935	51.7013
2025	11	27	7	21	10	11.8	0.1	0.9	25.51	95.4	6.2935	52.9522
2025	11	27	7	31	10	11.8	0.1	0.9	26.28	96.8	6.2935	54.4115
2025	11	27	7	41	10	11.8	0.1	0.9	25.33	95.9	6.2935	52.5353
2025	11	27	7	51	10	11.8	0.1	0.9	25.01	95.3	6.2935	51.9098

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	27	8	1	10	11.8	0.1	0.9	24.42	95.6	6.2935	50.659
2025	11	27	8	11	10	11.8	0.1	0.9	24.65	93.5	6.2935	51.2844
2025	11	27	8	21	10	11.8	0.1	0.9	24.85	96.2	6.2935	51.4929
2025	11	27	8	31	10	12.2	0.1	0.9	25.24	98	6.2935	52.1183
2025	11	27	8	41	10	12	0.1	0.9	25.07	96.6	6.2935	51.9098
2025	11	27	8	51	10	12.2	0.1	0.9	24.83	95.8	6.2935	51.4929
2025	11	27	9	1	10	12.2	0.1	0.9	23.88	94.8	6.2935	49.6166
2025	11	27	9	11	10	12.4	0.1	0.9	24.55	93.7	6.2935	51.0759
2025	11	27	9	21	10	12.8	0.1	0.9	25.31	95.4	6.2935	52.5352
2025	11	27	9	31	10	12.6	0.1	0.9	24.24	96.2	6.2935	50.242
2025	11	27	9	41	10	12.6	0.1	0.9	25.36	96.3	6.2935	52.5351
2025	11	27	9	51	10	12.8	0.1	0.9	26.12	95.5	6.2935	54.2029
2025	11	27	10	1	10	12.8	0.1	0.9	25.43	92.9	6.2935	52.952
2025	11	27	10	11	10	12.8	0.1	0.9	25.42	95.6	6.2935	52.7435
2025	11	27	10	21	10	12.6	0.1	0.9	24.57	96.8	6.2935	50.8673
2025	11	27	10	31	10	12.6	0.1	0.9	24.67	94.2	6.2935	51.2842
2025	11	27	10	41	10	12.6	0.1	0.9	25.36	96.3	6.2935	52.535
2025	11	27	10	51	10	12.6	0.1	0.9	25.81	95.3	6.2935	53.5773
2025	11	27	11	1	10	12.8	0.1	0.9	24.55	93.7	6.2996	51.1272
2025	11	27	11	11	10	13	0.1	0.9	25.43	92.7	6.2935	52.9518
2025	11	27	11	21	10	13	0.1	0.9	23.74	93.4	6.2996	49.4577
2025	11	27	11	31	10	13.4	0.1	0.9	25.81	95.3	6.2996	53.6313
2025	11	27	11	41	10	13.4	0.1	0.9	25.19	94.8	6.2996	52.3792
2025	11	27	11	51	10	13.2	0.1	0.9	25.17	96.6	6.2996	52.1704
2025	11	27	12	1	10	13.8	0.1	0.9	25.03	92.7	6.2996	52.1704
2025	11	27	12	11	10	13.8	0.1	0.9	25.98	94.6	6.2996	54.0485
2025	11	27	12	21	10	13.6	0.1	0.9	25.85	96.2	6.2996	53.6311
2025	11	27	12	31	10	13.4	0.1	0.9	25.84	96	6.2996	53.6311
2025	11	27	12	41	10	13.6	0.1	0.9	25.27	94.3	6.2996	52.5876
2025	11	27	12	51	10	14.2	0.1	0.9	24.96	93.9	6.2996	51.9615
2025	11	27	13	1	10	14.2	0.1	0.9	25.25	93.6	6.2996	52.5875
2025	11	27	13	11	10	14	0.1	0.9	25.2	95	6.3057	52.4316
2025	11	27	13	21	10	14.2	0.1	0.9	26.23	95.7	6.3057	54.5205
2025	11	27	13	31	10	14.2	0.1	0.9	24.49	94.9	6.3057	50.9693
2025	11	27	13	41	10	14.2	0.1	0.9	24.91	95.3	6.3057	51.8048
2025	11	27	13	51	10	14	0.1	0.9	24.83	92.8	6.3057	51.8048
2025	11	27	14	1	10	14	0.1	0.9	24.94	96	6.3057	51.8048
2025	11	27	14	11	10	14.2	0.1	0.9	24.47	94.5	6.3057	50.9691
2025	11	27	14	21	10	13.4	0.1	0.9	24.99	94.8	6.3057	52.0136
2025	11	27	14	31	10	13.4	0.1	0.9	25.13	95.9	6.3057	52.2224
2025	11	27	14	41	10	13.4	0.1	0.9	24.73	95.8	6.3057	51.3868
2025	11	27	14	51	10	13.4	0.1	0.9	25.95	96.2	6.3057	53.8935
2025	11	27	15	1	10	13.2	0.1	0.9	25.03	95.7	6.3057	52.0134
2025	11	27	15	11	10	13.4	0.1	0.9	24.95	93.7	6.3057	52.0134
2025	11	27	15	21	10	12.8	0.1	0.9	25.06	94.1	6.3057	52.2223
2025	11	27	15	31	10	12.8	0.1	0.9	25.01	95.3	6.3057	52.0134
2025	11	27	15	41	10	12.8	0.1	0.9	25.74	96	6.3057	53.4756
2025	11	27	15	51	10	12.8	0.1	0.9	24.7	95.1	6.3057	51.3867

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	27	16	1	10	12.8	0.1	0.9	25.95	96.2	6.3057	53.8933
2025	11	27	16	11	10	12.6	0.1	0.9	24.69	94.9	6.3057	51.3866
2025	11	27	16	21	10	12.6	0.1	0.9	24.99	94.8	6.3057	52.0133
2025	11	27	16	31	10	12.6	0.1	0.9	25.01	95.3	6.3057	52.0133
2025	11	27	16	41	10	12.4	0.1	0.9	25.61	97.4	6.3057	53.0577
2025	11	27	16	51	10	12.4	0.1	0.9	25.42	92	6.3057	53.0577
2025	11	27	17	1	10	12.2	0.1	0.9	25.37	98.4	6.3057	52.431
2025	11	27	17	11	10	12.2	0.1	0.9	25.24	93.4	6.3057	52.6399
2025	11	27	17	21	10	12.2	0.1	0.9	24.57	94.4	6.3057	51.1777
2025	11	27	17	31	10	12.2	0.1	0.9	25.6	95.2	6.3057	53.2666
2025	11	27	17	41	10	12.2	0.1	0.9	25.09	97.1	6.3057	52.0133
2025	11	27	17	51	10	12.2	0.1	0.9	25.66	96.5	6.3057	53.2666
2025	11	27	18	1	10	12.2	0.1	0.9	25.51	95.4	6.3057	53.0577
2025	11	27	18	11	10	12.2	0.1	0.9	26.19	94.8	6.3057	54.52
2025	11	27	18	21	10	12	0.1	0.9	26.65	93.7	6.3057	55.5644
2025	11	27	18	31	10	12	0.1	0.9	25.75	93.6	6.3057	53.6844
2025	11	27	18	41	10	12	0.1	0.9	25.65	96.3	6.3057	53.2667
2025	11	27	18	51	10	12	0.1	0.9	25.56	94	6.3057	53.2667
2025	11	27	19	1	10	12	0.1	0.9	25.27	96.6	6.3057	52.4311
2025	11	27	19	11	10	12	0.1	0.9	24.85	93.7	6.3057	51.8045
2025	11	27	19	21	10	12	0.1	0.9	25.2	91.1	6.3057	52.6401
2025	11	27	19	31	10	12	0.1	0.9	25.12	95.7	6.3057	52.2223
2025	11	27	19	41	10	12	0.1	0.9	25.89	96.9	6.3057	53.6846
2025	11	27	19	51	10	12	0.1	0.9	25.03	93	6.3057	52.2224
2025	11	27	20	1	10	12	0.1	0.9	24.63	95.8	6.3057	51.1779
2025	11	27	20	11	10	12	0.1	0.9	24.94	93.2	6.3057	52.0135
2025	11	27	20	21	10	12	0.1	0.9	25.45	93.6	6.3057	53.058
2025	11	27	20	31	10	12	0.1	0.9	25.31	95.4	6.3057	52.6402
2025	11	27	20	41	10	12	0.1	0.9	25.2	95	6.3057	52.4314
2025	11	27	20	51	10	12	0.1	0.9	24.44	93.3	6.3057	50.9692
2025	11	27	21	1	10	12	0.1	0.9	25.71	95.4	6.3057	53.4759
2025	11	27	21	11	10	12	0.1	0.9	26.32	95.5	6.3057	54.7293
2025	11	27	21	21	10	12	0.1	0.9	24.33	95.9	6.3057	50.5515
2025	11	27	21	31	10	12	0.1	0.9	24.47	96.8	6.3057	50.7604
2025	11	27	21	41	10	12	0.1	0.9	26.06	96.4	6.3057	54.1027
2025	11	27	21	51	10	12	0.1	0.9	25.31	95.4	6.3057	52.6405
2025	11	27	22	1	10	12	0.1	0.9	25.3	95.2	6.3057	52.6405
2025	11	27	22	11	10	12	0.1	0.9	24.07	94.3	6.3057	50.1338
2025	11	27	22	21	10	12	0.1	0.9	24.78	94.6	6.3057	51.5961
2025	11	27	22	31	10	12	0.1	0.9	25.6	95.2	6.2996	53.2135
2025	11	27	22	41	10	12	0.1	0.9	24.35	93.8	6.3057	50.7606
2025	11	27	22	51	10	12	0.1	0.9	25.21	95.5	6.3057	52.4317
2025	11	27	23	1	10	12	0.1	0.9	25.84	96	6.3057	53.6851
2025	11	27	23	11	10	12	0.1	0.9	25.49	97	6.2996	52.7963
2025	11	27	23	21	10	12	0.1	0.9	25.48	94.5	6.2996	53.005
2025	11	27	23	31	10	12	0.1	0.9	26.4	95	6.2996	54.8831
2025	11	27	23	41	10	11.8	0.1	0.9	24.32	95.7	6.2996	50.5009
2025	11	27	23	51	10	11.8	0.1	0.9	26.12	95.5	6.2996	54.2571

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	28	0	1	10	11.8	0.1	0.9	25.15	93.6	6.2996	52.379
2025	11	28	0	11	10	11.8	0.1	0.9	25.58	96.7	6.2996	53.0051
2025	11	28	0	21	10	11.8	0.1	0.9	25.4	95.2	6.2996	52.7964
2025	11	28	0	31	10	11.8	0.1	0.9	25.98	94.6	6.2996	54.0486
2025	11	28	0	41	10	11.8	0.1	0.9	25.79	96.9	6.2996	53.4226
2025	11	28	0	51	10	11.8	0.1	0.9	24.76	93.9	6.2996	51.5444
2025	11	28	1	1	10	11.8	0.1	0.9	26.04	93.3	6.2996	54.2573
2025	11	28	1	11	10	11.8	0.1	0.9	24.74	93.2	6.2996	51.5445
2025	11	28	1	21	10	11.8	0.1	0.9	25.31	95.4	6.2996	52.5879
2025	11	28	1	31	10	11.8	0.1	0.9	24.99	94.8	6.2996	51.9619
2025	11	28	1	41	10	11.8	0.1	0.9	24.69	94.9	6.2996	51.3359
2025	11	28	1	51	10	11.8	0.1	0.9	25.9	97.1	6.2996	53.6314
2025	11	28	2	1	10	11.8	0.1	0.9	24.13	92.6	6.2996	50.2925
2025	11	28	2	11	10	11.8	0.1	0.9	25.19	94.8	6.2996	52.3793
2025	11	28	2	21	10	11.8	0.1	0.9	25.73	95.8	6.2935	53.3689
2025	11	28	2	31	10	11.8	0.1	0.9	25.98	94.6	6.2935	53.9943
2025	11	28	2	41	10	11.8	0.1	0.9	25.72	95.6	6.2935	53.3689
2025	11	28	2	51	10	11.8	0.1	0.9	25.55	96.3	6.2935	52.952
2025	11	28	3	1	10	11.8	0.1	0.9	25.91	95.3	6.2935	53.7859
2025	11	28	3	11	10	11.8	0.1	0.9	25.06	96.4	6.2935	51.9096
2025	11	28	3	21	10	11.8	0.1	0.9	24.88	96.9	6.2935	51.4927
2025	11	28	3	31	10	11.8	0.1	0.9	26.84	97.7	6.2996	55.5097
2025	11	28	3	41	10	11.8	0.1	0.9	24.69	94.9	6.2935	51.2843
2025	11	28	3	51	10	11.8	0.1	0.9	25.38	94.5	6.2935	52.7436
2025	11	28	4	1	10	11.8	0.1	0.9	24.91	95.3	6.2935	51.7012
2025	11	28	4	11	10	11.8	0.1	0.9	25.45	93.6	6.2935	52.9521
2025	11	28	4	21	10	11.8	0.1	0.9	24.45	93.5	6.2935	50.8674
2025	11	28	4	31	10	11.8	0.1	0.9	24.56	94	6.2935	51.0759
2025	11	28	4	41	10	11.8	0.1	0.9	25.13	97.8	6.2935	51.9098
2025	11	28	4	51	10	11.8	0.1	0.9	24.95	93.4	6.2935	51.9098
2025	11	28	5	1	10	11.8	0.1	0.9	24.48	94.7	6.2935	50.8674
2025	11	28	5	11	10	11.8	0.1	0.9	24.93	95.8	6.2935	51.7013
2025	11	28	5	21	10	11.8	0.1	0.9	25.6	95.2	6.2935	53.1607
2025	11	28	5	31	10	11.8	0.1	0.9	25.46	94.1	6.2935	52.9522
2025	11	28	5	41	10	11.8	0.1	0.9	25.55	93.6	6.2935	53.1607
2025	11	28	5	51	10	11.8	0.1	0.9	24.49	94.9	6.2935	50.8675
2025	11	28	6	1	10	11.8	0.1	0.9	24.62	95.6	6.2935	51.076
2025	11	28	6	11	10	11.8	0.1	0.9	25.65	96.3	6.2935	53.1607
2025	11	28	6	21	10	11.8	0.1	0.9	24.82	95.5	6.2935	51.4929
2025	11	28	6	31	10	11.8	0.1	0.9	25.31	95.4	6.2935	52.5353
2025	11	28	6	41	10	11.8	0.1	0.9	24.77	94.4	6.2935	51.493
2025	11	28	6	51	10	11.8	0.1	0.9	24.14	93.1	6.2935	50.2421
2025	11	28	7	1	10	11.8	0.1	0.9	25.18	94.6	6.2935	52.3269
2025	11	28	7	11	10	11.8	0.1	0.9	25.97	96.6	6.2935	53.7862
2025	11	28	7	21	10	11.8	0.1	0.9	26.41	95.2	6.2935	54.8286
2025	11	28	7	31	10	11.8	0.1	0.9	25.39	97	6.2935	52.5354
2025	11	28	7	41	10	11.8	0.1	0.9	25.89	94.9	6.2935	53.7862
2025	11	28	7	51	10	11.8	0.1	0.9	24.35	93.8	6.2935	50.6591

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	28	8	1	10	11.8	0.1	0.9	25.08	94.6	6.2935	52.1185
2025	11	28	8	11	10	11.8	0.1	0.9	25.87	94.2	6.2935	53.7863
2025	11	28	8	21	10	11.8	0.1	0.9	24.88	96.9	6.2935	51.4931
2025	11	28	8	31	10	12	0.1	0.9	24.93	95.8	6.2935	51.7015
2025	11	28	8	41	10	12.4	0.1	0.9	23.84	93.1	6.2935	49.6168
2025	11	28	8	51	10	12.6	0.1	0.9	25.33	95.9	6.2935	52.5354
2025	11	28	9	1	10	12.6	0.1	0.9	24.73	93	6.2935	51.493
2025	11	28	9	11	10	12.8	0.1	0.9	24.33	93.1	6.2935	50.6591
2025	11	28	9	21	10	12.8	0.1	0.9	25.44	96.1	6.2935	52.7439
2025	11	28	9	31	10	12.8	0.1	0.9	26.04	93.3	6.2935	54.2031
2025	11	28	9	41	10	13	0.1	0.9	24.57	94.4	6.2935	51.076
2025	11	28	9	51	10	13	0.1	0.9	26.04	96	6.2935	53.9946
2025	11	28	10	1	10	13.4	0.1	0.9	25.3	95	6.2935	52.5353
2025	11	28	10	11	10	13.6	0.1	0.9	24.63	93	6.2935	51.2844
2025	11	28	10	21	10	13.8	0.1	0.9	25.68	96.7	6.2935	53.1607
2025	11	28	10	31	10	13.8	0.1	0.9	24.78	94.6	6.2935	51.4928
2025	11	28	10	41	10	13.8	0.1	0.9	25.55	93.6	6.2935	53.1606
2025	11	28	10	51	10	13.8	0.1	0.9	24.45	93.8	6.2935	50.8673
2025	11	28	11	1	10	13.8	0.1	0.9	25.32	95.7	6.2935	52.5351
2025	11	28	11	11	10	13.8	0.1	0.9	25.65	96.3	6.2935	53.1604
2025	11	28	11	21	10	13.6	0.1	0.9	24.67	94.2	6.2935	51.2842
2025	11	28	11	31	10	13.6	0.1	0.9	25.91	95.3	6.2935	53.7858
2025	11	28	11	41	10	13.6	0.1	0.9	23.7	95.3	6.2935	49.1993
2025	11	28	11	51	10	13.6	0.1	0.9	24.94	96	6.2935	51.701
2025	11	28	12	1	10	13.6	0.1	0.9	25.41	95.4	6.2935	52.7433
2025	11	28	12	11	10	13.6	0.1	0.9	25.68	94.5	6.2935	53.3686
2025	11	28	12	21	10	13.6	0.1	0.9	24.91	97.4	6.2935	51.4923
2025	11	28	12	31	10	13.6	0.1	0.9	25.73	95.8	6.2996	53.4224
2025	11	28	12	41	10	13.6	0.1	0.9	25.42	92	6.2996	53.005
2025	11	28	12	51	10	13.6	0.1	0.9	25.57	94.3	6.2996	53.2136
2025	11	28	13	1	10	13.6	0.1	0.9	24.48	94.7	6.2996	50.9181
2025	11	28	13	11	10	13.6	0.1	0.9	26.45	96.1	6.2996	54.883
2025	11	28	13	21	10	13.6	0.1	0.9	26.32	95.5	6.2996	54.6743
2025	11	28	13	31	10	13.6	0.1	0.9	25.61	95.4	6.2996	53.2135
2025	11	28	13	41	10	13.6	0.1	0.9	25.53	92.7	6.2996	53.2134
2025	11	28	13	51	10	13.6	0.1	0.9	24.81	95.3	6.2996	51.5439
2025	11	28	14	1	10	13.6	0.1	0.9	24.84	96	6.2996	51.5439
2025	11	28	14	11	10	13.6	0.1	0.9	25.32	95.7	6.2996	52.5872
2025	11	28	14	21	10	13.6	0.1	0.9	25.29	94.8	6.2996	52.5872
2025	11	28	14	31	10	13.4	0.1	0.9	25.08	94.6	6.2996	52.1698
2025	11	28	14	41	10	13.4	0.1	0.9	25.11	95.3	6.2996	52.1698
2025	11	28	14	51	10	13.4	0.1	0.9	25.03	95.7	6.2996	51.9611
2025	11	28	15	1	10	13.4	0.1	0.9	25.45	93.6	6.3057	53.0579
2025	11	28	15	11	10	13.4	0.1	0.9	25.76	93.8	6.3057	53.6846
2025	11	28	15	21	10	13.4	0.1	0.9	26.02	95.5	6.2996	54.0478
2025	11	28	15	31	10	13.4	0.1	0.9	26.69	94.7	6.3057	55.5645
2025	11	28	15	41	10	13.4	0.1	0.9	25.14	93.2	6.3057	52.4312
2025	11	28	15	51	10	13.4	0.1	0.9	25.66	93.8	6.3057	53.4756

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	28	16	1	10	13.2	0.1	0.9	24.97	94.4	6.3057	52.0134
2025	11	28	16	11	10	13	0.1	0.9	26.58	94.3	6.3057	55.3556
2025	11	28	16	21	10	12.8	0.1	0.9	25.53	97.7	6.3057	52.8489
2025	11	28	16	31	10	12.8	0.1	0.9	26.3	95	6.3057	54.7289
2025	11	28	16	41	10	12.6	0.1	0.9	25.19	94.8	6.3057	52.4311
2025	11	28	16	51	10	12.6	0.1	0.9	25.08	94.6	6.3057	52.2222
2025	11	28	17	1	10	12.2	0.1	0.9	26.45	93.5	6.3057	55.1466
2025	11	28	17	11	10	12.2	0.1	0.9	24.37	96.8	6.3057	50.5511
2025	11	28	17	21	10	12.2	0.1	0.9	25.48	96.8	6.3057	52.8488
2025	11	28	17	31	10	12.2	0.1	0.9	25.18	96.8	6.3057	52.2222
2025	11	28	17	41	10	12.2	0.1	0.9	26.47	94.1	6.3057	55.1466
2025	11	28	17	51	10	12.2	0.1	0.9	25.4	95	6.3057	52.8488
2025	11	28	18	1	10	12.2	0.1	0.9	25.57	96.5	6.3057	53.0577
2025	11	28	18	11	10	12.2	0.1	0.9	24.97	96.7	6.3057	51.8044
2025	11	28	18	21	10	12.2	0.1	0.9	25.56	94	6.3057	53.2666
2025	11	28	18	31	10	12.2	0.1	0.9	25.53	95.8	6.3057	53.0577
2025	11	28	18	41	10	12	0.1	0.9	25.36	93.8	6.3057	52.8489
2025	11	28	18	51	10	12	0.1	0.9	25.87	96.7	6.3057	53.6844
2025	11	28	19	1	10	12	0.1	0.9	24.77	94.2	6.3057	51.5956
2025	11	28	19	11	10	12	0.1	0.9	24.27	94.3	6.3057	50.5511
2025	11	28	19	21	10	12	0.1	0.9	24.36	94	6.3057	50.76
2025	11	28	19	31	10	12	0.1	0.9	25.73	92.9	6.3057	53.6845
2025	11	28	19	41	10	12	0.1	0.9	25.39	94.7	6.3057	52.849
2025	11	28	19	51	10	12	0.1	0.9	25.54	96.1	6.3057	53.0579
2025	11	28	20	1	10	12	0.1	0.9	25.43	95.9	6.3057	52.849
2025	11	28	20	11	10	12	0.1	0.9	26.1	95.1	6.3057	54.3113
2025	11	28	20	21	10	12	0.1	0.9	25.21	95.5	6.3057	52.4313
2025	11	28	20	31	10	12	0.1	0.9	24.95	93.7	6.3057	52.0135
2025	11	28	20	41	10	12	0.1	0.9	24.77	94.2	6.3057	51.5958
2025	11	28	20	51	10	12	0.1	0.9	24.43	93	6.3057	50.9691
2025	11	28	21	1	10	12	0.1	0.9	24.25	96.4	6.3057	50.3425
2025	11	28	21	11	10	12	0.1	0.9	24.55	96.3	6.3057	50.9692
2025	11	28	21	21	10	12	0.1	0.9	24.83	92.8	6.2996	51.7525
2025	11	28	21	31	10	12	0.1	0.9	25.08	96.9	6.3057	52.0137
2025	11	28	21	41	10	12	0.1	0.9	24.46	94	6.3057	50.9693
2025	11	28	21	51	10	12	0.1	0.9	25.75	96.2	6.3057	53.476
2025	11	28	22	1	10	12	0.1	0.9	26.25	96.1	6.2996	54.4655
2025	11	28	22	11	10	12	0.1	0.9	26.11	95.3	6.2996	54.2568
2025	11	28	22	21	10	12	0.1	0.9	25.62	92.2	6.3057	53.4761
2025	11	28	22	31	10	12	0.1	0.9	24.35	93.8	6.2996	50.7093
2025	11	28	22	41	10	12	0.1	0.9	25.79	96.9	6.2996	53.4222
2025	11	28	22	51	10	12	0.1	0.9	25.23	92.7	6.2996	52.5875
2025	11	28	23	1	10	12	0.1	0.9	25.15	93.6	6.2996	52.3788
2025	11	28	23	11	10	12	0.1	0.9	24.77	94.2	6.2996	51.5441
2025	11	28	23	21	10	12	0.1	0.9	24.98	94.6	6.2996	51.9615
2025	11	28	23	31	10	12	0.1	0.9	25.86	94	6.2996	53.8397
2025	11	28	23	41	10	12	0.1	0.9	24.77	94.4	6.2996	51.5442
2025	11	28	23	51	10	12	0.1	0.9	25.64	93.4	6.2996	53.4224

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	29	0	1	10	12	0.1	0.9	24.35	93.5	6.2996	50.7095
2025	11	29	0	11	10	12	0.1	0.9	25.58	94.5	6.2996	53.2137
2025	11	29	0	21	10	12	0.1	0.9	23.83	92.9	6.2996	49.6662
2025	11	29	0	31	10	11.8	0.1	0.9	25.21	95.2	6.2996	52.379
2025	11	29	0	41	10	11.8	0.1	0.9	25.26	96.4	6.2996	52.3791
2025	11	29	0	51	10	11.8	0.1	0.9	25.94	96	6.2935	53.7855
2025	11	29	1	1	10	11.8	0.1	0.9	24.77	96.7	6.2996	51.3357
2025	11	29	1	11	10	11.8	0.1	0.9	24.68	94.6	6.2935	51.2839
2025	11	29	1	21	10	11.8	0.1	0.9	25.85	93.5	6.2935	53.7856
2025	11	29	1	31	10	11.8	0.1	0.9	26.59	94.7	6.2935	55.2449
2025	11	29	1	41	10	11.8	0.1	0.9	26.31	95.2	6.2935	54.6195
2025	11	29	1	51	10	11.8	0.1	0.9	25.84	96	6.2935	53.5772
2025	11	29	2	1	10	11.8	0.1	0.9	26.21	95.3	6.2935	54.4111
2025	11	29	2	11	10	11.8	0.1	0.9	24.95	93.4	6.2935	51.9095
2025	11	29	2	21	10	11.8	0.1	0.9	25.76	93.8	6.2935	53.5772
2025	11	29	2	31	10	11.8	0.1	0.9	25.79	94.7	6.2935	53.5773
2025	11	29	2	41	10	11.8	0.1	0.9	24.66	96.5	6.2935	51.0756
2025	11	29	2	51	10	11.8	0.1	0.9	26.94	95.8	6.2935	55.8705
2025	11	29	3	1	10	11.8	0.1	0.9	26.24	95.9	6.2935	54.4112
2025	11	29	3	11	10	11.8	0.1	0.9	25.02	92.5	6.2935	52.118
2025	11	29	3	21	10	11.8	0.1	0.9	25.64	96	6.2935	53.1604
2025	11	29	3	31	10	11.8	0.1	0.9	24.37	94.2	6.2935	50.6588
2025	11	29	3	41	10	11.8	0.1	0.9	25.35	93.6	6.2935	52.7435
2025	11	29	3	51	10	11.8	0.1	0.9	25.78	94.4	6.2935	53.5774
2025	11	29	4	1	10	11.8	0.1	0.9	25.65	98.1	6.2935	52.952
2025	11	29	4	11	10	11.8	0.1	0.9	24.96	94.1	6.2935	51.9097
2025	11	29	4	21	10	11.8	0.1	0.9	25.51	95.4	6.2935	52.952
2025	11	29	4	31	10	11.8	0.1	0.9	25.78	94.4	6.2935	53.5775
2025	11	29	4	41	10	11.8	0.1	0.9	24.88	94.6	6.2935	51.7012
2025	11	29	4	51	10	11.8	0.1	0.9	24.96	96.4	6.2874	51.649
2025	11	29	5	1	10	11.8	0.1	0.9	25.04	96	6.2874	51.8573
2025	11	29	5	11	10	11.8	0.1	0.9	25.12	95.7	6.2935	52.1182
2025	11	29	5	21	10	11.8	0.1	0.9	24.92	95.5	6.2874	51.649
2025	11	29	5	31	10	11.8	0.1	0.9	24.52	97.7	6.2935	50.6589
2025	11	29	5	41	10	11.8	0.1	0.9	25.08	94.6	6.2874	52.0656
2025	11	29	5	51	10	11.8	0.1	0.9	24.65	93.7	6.2874	51.2325
2025	11	29	6	1	10	11.8	0.1	0.9	25.15	96.2	6.2874	52.0656
2025	11	29	6	11	10	11.8	0.1	0.9	24.35	93.8	6.2935	50.659
2025	11	29	6	21	10	11.8	0.1	0.9	25.72	95.6	6.2874	53.3152
2025	11	29	6	31	10	11.8	0.1	0.9	26.33	95.7	6.2874	54.5648
2025	11	29	6	41	10	11.8	0.1	0.9	25.28	96.8	6.2874	52.2739
2025	11	29	6	51	10	11.8	0.1	0.9	24.33	93.1	6.2874	50.6078
2025	11	29	7	1	10	11.8	0.1	0.9	24.69	94.9	6.2874	51.2326
2025	11	29	7	11	10	11.8	0.1	0.9	24.41	95.4	6.2874	50.6078
2025	11	29	7	21	10	11.8	0.1	0.9	25.24	93.4	6.2874	52.4822
2025	11	29	7	31	10	11.8	0.1	0.9	25.08	94.6	6.2874	52.0657
2025	11	29	7	41	10	11.8	0.1	0.9	24.71	95.3	6.2874	51.2326
2025	11	29	7	51	10	11.8	0.1	0.9	25.16	96.4	6.2874	52.0657

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	29	8	1	10	11.8	0.1	0.9	25.33	95.9	6.2874	52.4822
2025	11	29	8	11	10	11.8	0.1	0.9	25.11	95.5	6.2874	52.0657
2025	11	29	8	21	10	11.8	0.1	0.9	24.79	94.9	6.2874	51.4409
2025	11	29	8	31	10	12	0.1	0.9	24.84	96	6.2874	51.4409
2025	11	29	8	41	10	12.2	0.1	0.9	25.64	96	6.2874	53.107
2025	11	29	8	51	10	12.2	0.1	0.9	26.3	95	6.2874	54.5648
2025	11	29	9	1	10	12.4	0.1	0.9	25.3	95.2	6.2874	52.4822
2025	11	29	9	11	10	12.6	0.1	0.9	24.6	95.1	6.2874	51.0243
2025	11	29	9	21	10	13	0.1	0.9	25.62	95.6	6.2874	53.1069
2025	11	29	9	31	10	13	0.1	0.9	25.19	94.8	6.2874	52.2739
2025	11	29	9	41	10	13.2	0.1	0.9	25.56	93.8	6.2874	53.1069
2025	11	29	9	51	10	12.8	0.1	0.9	24.52	97.7	6.2874	50.6077
2025	11	29	10	1	10	12.6	0.1	0.9	25.92	95.5	6.2874	53.7316
2025	11	29	10	11	10	12.6	0.1	0.9	25.2	97.3	6.2874	52.0655
2025	11	29	10	21	10	12.8	0.1	0.9	24.89	94.8	6.2935	51.7012
2025	11	29	10	31	10	12.6	0.1	0.9	24.18	94.7	6.2874	50.1911
2025	11	29	10	41	10	12.6	0.1	0.9	24.86	96.5	6.2935	51.4927
2025	11	29	10	51	10	12.6	0.1	0.9	24.45	93.8	6.2935	50.8672
2025	11	29	11	1	10	12.6	0.1	0.9	24.54	93.3	6.2935	51.0757
2025	11	29	11	11	10	12.6	0.1	0.9	24.95	93.7	6.2935	51.9095
2025	11	29	11	21	10	12.6	0.1	0.9	24.58	94.7	6.2935	51.0756
2025	11	29	11	31	10	12.6	0.1	0.9	24.76	96.5	6.2935	51.2841
2025	11	29	11	41	10	12.6	0.1	0.9	24.66	96.5	6.2935	51.0756
2025	11	29	11	51	10	12.6	0.1	0.9	25.29	97	6.2935	52.3264
2025	11	29	12	1	10	12.6	0.1	0.9	25.55	96.3	6.2935	52.9517
2025	11	29	12	11	10	12.8	0.1	0.9	24.54	93.3	6.2935	51.0754
2025	11	29	12	21	10	12.8	0.1	0.9	24.91	95.3	6.2935	51.7008
2025	11	29	12	31	10	12.8	0.1	0.9	24.48	94.7	6.2935	50.8669
2025	11	29	12	41	10	12.8	0.1	0.9	25.05	93.7	6.2935	52.1177
2025	11	29	12	51	10	12.8	0.1	0.9	24.39	97.1	6.2996	50.5009
2025	11	29	13	1	10	12.8	0.1	0.9	25.06	94.1	6.2935	52.1176
2025	11	29	13	11	10	12.8	0.1	0.9	25.65	96.3	6.2996	53.2137
2025	11	29	13	21	10	13.2	0.1	0.9	25.63	92.9	6.2996	53.4223
2025	11	29	13	31	10	13.6	0.1	0.9	26.04	96	6.2996	54.0483
2025	11	29	13	41	10	13.6	0.1	0.9	24.29	97.1	6.2996	50.292
2025	11	29	13	51	10	13.6	0.1	0.9	25.25	93.6	6.2996	52.5875
2025	11	29	14	1	10	13.6	0.1	0.9	25.25	93.6	6.2996	52.5874
2025	11	29	14	11	10	13.6	0.1	0.9	25.62	92.2	6.2996	53.4221
2025	11	29	14	21	10	13.6	0.1	0.9	24.53	92.8	6.2996	51.1266
2025	11	29	14	31	10	13.6	0.1	0.9	24.53	95.9	6.2996	50.9179
2025	11	29	14	41	10	13.6	0.1	0.9	25.51	95.4	6.2996	53.0047
2025	11	29	14	51	10	13.6	0.1	0.9	26.09	94.8	6.2996	54.2567
2025	11	29	15	1	10	13.4	0.1	0.9	26.32	95.5	6.2996	54.6741
2025	11	29	15	11	10	13.4	0.1	0.9	24.96	93.9	6.2996	51.9612
2025	11	29	15	21	10	13.4	0.1	0.9	25.19	94.8	6.2996	52.3785
2025	11	29	15	31	10	13.4	0.1	0.9	26.28	94.4	6.2996	54.674
2025	11	29	15	41	10	13.4	0.1	0.9	25.2	95	6.2996	52.3785
2025	11	29	15	51	10	13.4	0.1	0.9	25.39	94.7	6.2996	52.7959

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	29	16	1	10	13.4	0.1	0.9	25	95	6.2996	51.9612
2025	11	29	16	11	10	13.4	0.1	0.9	25.46	93.8	6.2996	53.0045
2025	11	29	16	21	10	13	0.1	0.9	25.47	94.3	6.2996	53.0045
2025	11	29	16	31	10	12.8	0.1	0.9	24.99	94.8	6.3057	52.0136
2025	11	29	16	41	10	12.8	0.1	0.9	25.71	95.4	6.3057	53.4758
2025	11	29	16	51	10	12.6	0.1	0.9	25.74	96	6.2996	53.4219
2025	11	29	17	1	10	12.2	0.1	0.9	25.32	92.5	6.3057	52.8491
2025	11	29	17	11	10	12.2	0.1	0.9	25.14	93.2	6.3057	52.4313
2025	11	29	17	21	10	12.2	0.1	0.9	25.96	93.8	6.3057	54.1025
2025	11	29	17	31	10	12.2	0.1	0.9	25.36	94.1	6.3057	52.8491
2025	11	29	17	41	10	12.2	0.1	0.9	24.53	92.8	6.3057	51.178
2025	11	29	17	51	10	12.2	0.1	0.9	25.96	96.4	6.3057	53.8936
2025	11	29	18	1	10	12.2	0.1	0.9	25.35	93.6	6.3057	52.8491
2025	11	29	18	11	10	12	0.1	0.9	25.5	95	6.3057	53.058
2025	11	29	18	21	10	12	0.1	0.9	24.87	94.2	6.3057	51.8047
2025	11	29	18	31	10	12	0.1	0.9	25	95	6.3057	52.0136
2025	11	29	18	41	10	12	0.1	0.9	25.82	95.6	6.3057	53.6847
2025	11	29	18	51	10	12	0.1	0.9	26.55	96.1	6.3057	55.147
2025	11	29	19	1	10	12	0.1	0.9	24.47	94.5	6.3057	50.9692
2025	11	29	19	11	10	12	0.1	0.9	25.31	95.4	6.3057	52.6403
2025	11	29	19	21	10	12	0.1	0.9	25.39	94.7	6.3057	52.8493
2025	11	29	19	31	10	12	0.1	0.9	26.47	94.1	6.3057	55.1471
2025	11	29	19	41	10	12	0.1	0.9	24.35	93.8	6.3057	50.7604
2025	11	29	19	51	10	12	0.1	0.9	25.82	95.6	6.3057	53.6849
2025	11	29	20	1	10	12	0.1	0.9	25.51	97.4	6.3057	52.8493
2025	11	29	20	11	10	12	0.1	0.9	25.3	95	6.3057	52.6405
2025	11	29	20	21	10	12	0.1	0.9	25.36	94.1	6.3057	52.8494
2025	11	29	20	31	10	12	0.1	0.9	24.27	94.3	6.3057	50.5516
2025	11	29	20	41	10	12	0.1	0.9	25.8	97.1	6.3057	53.4761
2025	11	29	20	51	10	12	0.1	0.9	25.47	94.3	6.3057	53.0584
2025	11	29	21	1	10	12	0.1	0.9	25.3	97.3	6.3057	52.4317
2025	11	29	21	11	10	12	0.1	0.9	25.61	95.4	6.3057	53.2673
2025	11	29	21	21	10	12	0.1	0.9	26.01	95.3	6.3057	54.1029
2025	11	29	21	31	10	12	0.1	0.9	24.55	96.3	6.3057	50.9696
2025	11	29	21	41	10	12	0.1	0.9	25.49	94.7	6.3057	53.0585
2025	11	29	21	51	10	12	0.1	0.9	26.2	95	6.3057	54.5208
2025	11	29	22	1	10	12	0.1	0.9	25.38	94.5	6.3057	52.8497
2025	11	29	22	11	10	12	0.1	0.9	25.16	94.1	6.3057	52.4319
2025	11	29	22	21	10	12	0.1	0.9	25.15	96.2	6.3057	52.223
2025	11	29	22	31	10	12	0.1	0.9	25.38	94.5	6.3057	52.8497
2025	11	29	22	41	10	12	0.1	0.9	25.59	94.9	6.2996	53.2138
2025	11	29	22	51	10	12	0.1	0.9	25.48	94.5	6.2996	53.0052
2025	11	29	23	1	10	12	0.1	0.9	25.85	96.2	6.2996	53.6312
2025	11	29	23	11	10	11.8	0.1	0.9	26.06	93.7	6.2996	54.2573
2025	11	29	23	21	10	11.8	0.1	0.9	24.38	94.7	6.2996	50.7097
2025	11	29	23	31	10	11.8	0.1	0.9	26.84	93	6.2996	55.9268
2025	11	29	23	41	10	11.8	0.1	0.9	25.21	95.2	6.2996	52.3792
2025	11	29	23	51	10	11.8	0.1	0.9	25.46	93.8	6.2996	53.0053

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	30	0	1	10	11.8	0.1	0.9	25.65	96.3	6.2996	53.214
2025	11	30	0	11	10	11.8	0.1	0.9	25.55	93.6	6.2996	53.214
2025	11	30	0	21	10	11.8	0.1	0.9	24.72	95.6	6.2996	51.3359
2025	11	30	0	31	10	11.8	0.1	0.9	25.96	94	6.2996	54.0488
2025	11	30	0	41	10	11.8	0.1	0.9	25.66	94	6.2996	53.4228
2025	11	30	0	51	10	11.8	0.1	0.9	25.42	95.6	6.2996	52.7968
2025	11	30	1	1	10	11.8	0.1	0.9	24.85	96.2	6.2996	51.5447
2025	11	30	1	11	10	11.8	0.1	0.9	24.89	94.8	6.2996	51.7534
2025	11	30	1	21	10	11.8	0.1	0.9	25.7	95.1	6.2996	53.4229
2025	11	30	1	31	10	11.8	0.1	0.9	25.3	95.2	6.2935	52.5351
2025	11	30	1	41	10	11.8	0.1	0.9	25.74	96	6.2935	53.369
2025	11	30	1	51	10	11.8	0.1	0.9	25.05	93.7	6.2935	52.1182
2025	11	30	2	1	10	11.8	0.1	0.9	25.34	93.2	6.2935	52.7437
2025	11	30	2	11	10	11.8	0.1	0.9	25.86	93.8	6.2935	53.786
2025	11	30	2	21	10	11.8	0.1	0.9	25.06	96.4	6.2935	51.9098
2025	11	30	2	31	10	11.8	0.1	0.9	25.26	93.9	6.2935	52.5353
2025	11	30	2	41	10	11.8	0.1	0.9	25.78	94.4	6.2935	53.5776
2025	11	30	2	51	10	11.8	0.1	0.9	24.26	94	6.2935	50.4506
2025	11	30	3	1	10	11.8	0.1	0.9	25.49	94.7	6.2935	52.9523
2025	11	30	3	11	10	11.8	0.1	0.9	25.22	92.5	6.2935	52.5353
2025	11	30	3	21	10	11.8	0.1	0.9	25.16	98.2	6.2935	51.9099
2025	11	30	3	31	10	11.8	0.1	0.9	25.67	94.2	6.2935	53.3693
2025	11	30	3	41	10	11.8	0.1	0.9	24.93	95.8	6.2935	51.7015
2025	11	30	3	51	10	11.8	0.1	0.9	25.17	94.3	6.2935	52.3269
2025	11	30	4	1	10	11.8	0.1	0.9	25.57	96.5	6.2935	52.9524
2025	11	30	4	11	10	11.8	0.1	0.9	24.98	94.6	6.2874	51.8576
2025	11	30	4	21	10	11.8	0.1	0.9	26.06	96.4	6.2935	53.9948
2025	11	30	4	31	10	11.8	0.1	0.9	24.85	93.7	6.2874	51.6493
2025	11	30	4	41	10	11.8	0.1	0.9	26.04	97.7	6.2874	53.732
2025	11	30	4	51	10	11.8	0.1	0.9	25.09	97.1	6.2874	51.8576
2025	11	30	5	1	10	11.8	0.1	0.9	24.67	94.2	6.2874	51.2328
2025	11	30	5	11	10	11.8	0.1	0.9	24.96	96.4	6.2874	51.6494
2025	11	30	5	21	10	11.8	0.1	0.9	24.28	94.7	6.2874	50.3998
2025	11	30	5	31	10	11.8	0.1	0.9	25.1	95	6.2874	52.0659
2025	11	30	5	41	10	11.8	0.1	0.9	26.17	94.2	6.2874	54.3568
2025	11	30	5	51	10	11.8	0.1	0.9	25.26	94.1	6.2874	52.4825
2025	11	30	6	1	10	11.8	0.1	0.9	25.28	96.8	6.2874	52.2742
2025	11	30	6	11	10	11.8	0.1	0.9	25.01	97.4	6.2874	51.6494
2025	11	30	6	21	10	11.8	0.1	0.9	25.14	93.2	6.2874	52.2742
2025	11	30	6	31	10	11.8	0.1	0.9	24.98	96.9	6.2874	51.6495
2025	11	30	6	41	10	11.8	0.1	0.9	24.45	93.8	6.2874	50.8164
2025	11	30	6	51	10	11.8	0.1	0.9	26.38	96.7	6.2874	54.5652
2025	11	30	7	1	10	11.8	0.1	0.9	25.55	96.3	6.2874	52.8991
2025	11	30	7	11	10	11.8	0.1	0.9	25.33	95.9	6.2874	52.4825
2025	11	30	7	21	10	11.8	0.1	0.9	24.19	95	6.2874	50.1916
2025	11	30	7	31	10	11.8	0.1	0.9	25.92	95.5	6.2874	53.7321
2025	11	30	7	41	10	11.8	0.1	0.9	25.52	95.6	6.2874	52.8991
2025	11	30	7	51	10	11.8	0.1	0.9	24.75	96.3	6.2874	51.233

Mazourka (0354)												
Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	30	8	1	10	11.8	0.1	0.9	24.38	94.7	6.2874	50.6082
2025	11	30	8	11	10	11.8	0.1	0.9	25.02	95.5	6.2874	51.8578
2025	11	30	8	21	10	11.8	0.1	0.9	24.21	95.5	6.2874	50.1917
2025	11	30	8	31	10	11.8	0.1	0.9	25.83	95.8	6.2874	53.5239
2025	11	30	8	41	10	11.8	0.1	0.9	25.28	94.5	6.2874	52.4826
2025	11	30	8	51	10	11.8	0.1	0.9	25.96	93.8	6.2874	53.9405
2025	11	30	9	1	10	12	0.1	0.9	24.45	93.8	6.2874	50.8165
2025	11	30	9	11	10	11.8	0.1	0.9	24.63	93	6.2874	51.233
2025	11	30	9	21	10	12	0.1	0.9	23.78	94.8	6.2874	49.3587
2025	11	30	9	31	10	12.8	0.1	0.9	25.56	94	6.2874	53.1074
2025	11	30	9	41	10	12.6	0.1	0.9	25.86	94	6.2874	53.7322
2025	11	30	9	51	10	12.6	0.1	0.9	25.97	94.2	6.2874	53.9404
2025	11	30	10	1	10	12.6	0.1	0.9	25.53	95.8	6.2874	52.8991
2025	11	30	10	11	10	13.8	0.1	0.9	24.95	96.2	6.2874	51.6495
2025	11	30	10	21	10	13	0.1	0.9	26.05	97.9	6.2874	53.7321
2025	11	30	10	31	10	13	0.1	0.9	24.36	94	6.2874	50.6081
2025	11	30	10	41	10	12.8	0.1	0.9	24.82	95.5	6.2874	51.4411
2025	11	30	10	51	10	12.6	0.1	0.9	25.45	96.3	6.2874	52.6907
2025	11	30	11	1	10	12.8	0.1	0.9	26.08	96.8	6.2874	53.9403
2025	11	30	11	11	10	13.2	0.1	0.9	25.09	97.1	6.2874	51.8576
2025	11	30	11	21	10	13.2	0.1	0.9	24.95	96.2	6.2874	51.6493
2025	11	30	11	31	10	14.2	0.1	0.9	24.48	94.7	6.2874	50.8162
2025	11	30	11	41	10	13.8	0.1	0.9	24.4	95.2	6.2935	50.6591
2025	11	30	11	51	10	13.8	0.1	0.9	24.75	93.7	6.2935	51.493
2025	11	30	12	1	10	14	0.1	0.9	26.44	93	6.2935	55.037
2025	11	30	12	11	10	14.2	0.1	0.9	26.25	96.1	6.2935	54.4115
2025	11	30	12	21	10	14.2	0.1	0.9	24.41	91.6	6.2935	50.8674
2025	11	30	12	31	10	14.2	0.1	0.9	25.41	91.6	6.2935	52.952
2025	11	30	12	41	10	14.2	0.1	0.9	24.89	94.8	6.2935	51.7012
2025	11	30	12	51	10	14.2	0.1	0.9	25.68	94.5	6.2935	53.3689
2025	11	30	13	1	10	14	0.1	0.9	24.92	97.6	6.2935	51.4927
2025	11	30	13	11	10	14	0.1	0.9	26.55	96.1	6.2935	55.0367
2025	11	30	13	21	10	14.2	0.1	0.9	24.69	94.9	6.2935	51.2841
2025	11	30	13	31	10	14.2	0.1	0.9	24.91	95.3	6.2935	51.701
2025	11	30	13	41	10	14.2	0.1	0.9	24.77	96.7	6.2935	51.284
2025	11	30	13	51	10	14.2	0.1	0.9	25.53	95.8	6.2935	52.9518
2025	11	30	14	1	10	14.2	0.1	0.9	24.53	95.9	6.2996	50.9184
2025	11	30	14	11	10	14.2	0.1	0.9	25.08	94.6	6.2996	52.1705
2025	11	30	14	21	10	13.6	0.1	0.9	26.06	96.4	6.2996	54.0486
2025	11	30	14	31	10	14	0.1	0.9	24.77	96.7	6.2996	51.3357
2025	11	30	14	41	10	14.2	0.1	0.9	25.93	95.8	6.2996	53.8398
2025	11	30	14	51	10	14.2	0.1	0.9	26.08	96.8	6.2996	54.0485
2025	11	30	15	1	10	14.2	0.1	0.9	26.48	94.3	6.2996	55.0919
2025	11	30	15	11	10	14.2	0.1	0.9	25.58	96.7	6.2996	53.005
2025	11	30	15	21	10	14.2	0.1	0.9	25.58	94.5	6.2996	53.2137
2025	11	30	15	31	10	14.2	0.1	0.9	24.72	95.6	6.2996	51.3356
2025	11	30	15	41	10	13.8	0.1	0.9	25.79	94.9	6.2996	53.6311
2025	11	30	15	51	10	14.2	0.1	0.9	25.93	95.8	6.2996	53.8397

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Voltage	CellBegin	CellEnd	Speed	Direction	Area	Flow
2025	11	30	16	1	10	14	0.1	0.9	25.16	96.4	6.2996	52.1703
2025	11	30	16	11	10	14	0.1	0.9	25.82	95.6	6.2996	53.6311
2025	11	30	16	21	10	13.2	0.1	0.9	25.3	95	6.2996	52.5876
2025	11	30	16	31	10	12.8	0.1	0.9	25.58	94.5	6.2996	53.2137
2025	11	30	16	41	10	12.8	0.1	0.9	25.12	95.7	6.2996	52.1703
2025	11	30	16	51	10	12.6	0.1	0.9	25.28	94.5	6.2996	52.5876
2025	11	30	17	1	10	12.2	0.1	0.9	24.68	94.6	6.2996	51.3355
2025	11	30	17	11	10	12.2	0.1	0.9	24.83	95.8	6.2996	51.5442
2025	11	30	17	21	10	12.2	0.1	0.9	25.23	95.9	6.2996	52.3789
2025	11	30	17	31	10	12.2	0.1	0.9	25.89	94.7	6.2996	53.8397
2025	11	30	17	41	10	12.2	0.1	0.9	25.47	96.5	6.2996	52.7963
2025	11	30	17	51	10	12.2	0.1	0.9	25.54	96.1	6.3057	53.0585
2025	11	30	18	1	10	12.2	0.1	0.9	25.27	94.3	6.2996	52.5876
2025	11	30	18	11	10	12	0.1	0.9	25.88	94.4	6.2996	53.8397
2025	11	30	18	21	10	12	0.1	0.9	25.42	97.5	6.3057	52.6407
2025	11	30	18	31	10	12	0.1	0.9	24.32	95.7	6.2996	50.5009
2025	11	30	18	41	10	12	0.1	0.9	25.02	95.5	6.3057	52.0141
2025	11	30	18	51	10	12	0.1	0.9	25.56	94	6.2996	53.2137
2025	11	30	19	1	10	12	0.1	0.9	24.61	95.4	6.3057	51.1786
2025	11	30	19	11	10	12	0.1	0.9	25.05	96.2	6.3057	52.0141
2025	11	30	19	21	10	12	0.1	0.9	25.2	97.3	6.3057	52.2231
2025	11	30	19	31	10	12	0.1	0.9	25.6	97.2	6.2996	53.0051
2025	11	30	19	41	10	12	0.1	0.9	25.43	92.9	6.2996	53.0052
2025	11	30	19	51	10	12	0.1	0.9	26.14	95.9	6.3057	54.312
2025	11	30	20	1	10	12	0.1	0.9	25.41	95.4	6.2996	52.7965
2025	11	30	20	11	10	12	0.1	0.9	25.26	98.2	6.2996	52.1705
2025	11	30	20	21	10	12	0.1	0.9	25.3	95	6.3057	52.641
2025	11	30	20	31	10	12	0.1	0.9	25.18	96.8	6.2996	52.1705
2025	11	30	20	41	10	12	0.1	0.9	26.28	94.4	6.2996	54.6748
2025	11	30	20	51	10	12	0.1	0.9	25.73	95.8	6.3057	53.4766
2025	11	30	21	1	10	12	0.1	0.9	25.79	94.9	6.2996	53.6314
2025	11	30	21	11	10	12	0.1	0.9	26.15	96.1	6.2996	54.2575
2025	11	30	21	21	10	12	0.1	0.9	24.99	97.1	6.2996	51.7533
2025	11	30	21	31	10	12	0.1	0.9	25.03	95.7	6.2996	51.962
2025	11	30	21	41	10	12	0.1	0.9	23.73	96	6.2996	49.2492
2025	11	30	21	51	10	12	0.1	0.9	24.95	93.7	6.2996	51.9621
2025	11	30	22	1	10	12	0.1	0.9	23.96	94.1	6.3057	49.9256
2025	11	30	22	11	10	12	0.1	0.9	24.37	94.2	6.2996	50.71
2025	11	30	22	21	10	12	0.1	0.9	25.31	95.4	6.2996	52.5882
2025	11	30	22	31	10	12	0.1	0.9	25.44	93.4	6.2996	53.0056
2025	11	30	22	41	10	12	0.1	0.9	25.33	97.7	6.3057	52.4324
2025	11	30	22	51	10	12	0.1	0.9	26.19	94.8	6.3057	54.5214
2025	11	30	23	1	10	12	0.1	0.9	25.28	94.5	6.2996	52.5883
2025	11	30	23	11	10	12	0.1	0.9	24.14	93.1	6.3057	50.3435
2025	11	30	23	21	10	12	0.1	0.9	24.93	95.8	6.3057	51.8058
2025	11	30	23	31	10	12	0.1	0.9	24.41	95.4	6.3057	50.7614
2025	11	30	23	41	10	12	0.1	0.9	25.21	95.2	6.3057	52.4325
2025	11	30	23	51	10	12	0.1	0.9	24.33	95.9	6.3057	50.5525

Locust Ditch Return
Station 0215

Date	Flow (cfs)
11/1/2025	0
11/2/2025	0
11/3/2025	0
11/4/2025	0
11/5/2025	0
11/6/2025	0
11/7/2025	0
11/8/2025	0
11/9/2025	0
11/10/2025	0
11/11/2025	0
11/12/2025	0
11/13/2025	0
11/14/2025	0
11/15/2025	0
11/16/2025	0
11/17/2025	0
11/18/2025	0
11/19/2025	0
11/20/2025	0
11/21/2025	0
11/22/2025	0
11/23/2025	0
11/24/2025	0
11/25/2025	0
11/26/2025	0
11/27/2025	0
11/28/2025	0
11/29/2025	0
11/30/2025	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/1/2025	12:00:00 AM	0
11/1/2025	12:15:00 AM	0
11/1/2025	12:30:00 AM	0
11/1/2025	12:45:00 AM	0
11/1/2025	1:00:00 AM	0
11/1/2025	1:15:00 AM	0
11/1/2025	1:30:00 AM	0
11/1/2025	1:45:00 AM	0
11/1/2025	2:00:00 AM	0
11/1/2025	2:15:00 AM	0
11/1/2025	2:30:00 AM	0
11/1/2025	2:45:00 AM	0
11/1/2025	3:00:00 AM	0
11/1/2025	3:15:00 AM	0
11/1/2025	3:30:00 AM	0
11/1/2025	3:45:00 AM	0
11/1/2025	4:00:00 AM	0
11/1/2025	4:15:00 AM	0
11/1/2025	4:30:00 AM	0
11/1/2025	4:45:00 AM	0
11/1/2025	5:00:00 AM	0
11/1/2025	5:15:00 AM	0
11/1/2025	5:30:00 AM	0
11/1/2025	5:45:00 AM	0
11/1/2025	6:00:00 AM	0
11/1/2025	6:15:00 AM	0
11/1/2025	6:30:00 AM	0
11/1/2025	6:45:00 AM	0
11/1/2025	7:00:00 AM	0
11/1/2025	7:15:00 AM	0
11/1/2025	7:30:00 AM	0
11/1/2025	7:45:00 AM	0
11/1/2025	8:00:00 AM	0
11/1/2025	8:15:00 AM	0
11/1/2025	8:30:00 AM	0
11/1/2025	8:45:00 AM	0
11/1/2025	9:00:00 AM	0
11/1/2025	9:15:00 AM	0
11/1/2025	9:30:00 AM	0
11/1/2025	9:45:00 AM	0
11/1/2025	10:00:00 AM	0
11/1/2025	10:15:00 AM	0
11/1/2025	10:30:00 AM	0
11/1/2025	10:45:00 AM	0
11/1/2025	11:00:00 AM	0
11/1/2025	11:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/1/2025	11:30:00 AM	0
11/1/2025	11:45:00 AM	0
11/1/2025	12:00:00 PM	0
11/1/2025	12:15:00 PM	0
11/1/2025	12:30:00 PM	0
11/1/2025	12:45:00 PM	0
11/1/2025	1:00:00 PM	0
11/1/2025	1:15:00 PM	0
11/1/2025	1:30:00 PM	0
11/1/2025	1:45:00 PM	0
11/1/2025	2:00:00 PM	0
11/1/2025	2:15:00 PM	0
11/1/2025	2:30:00 PM	0
11/1/2025	2:45:00 PM	0
11/1/2025	3:00:00 PM	0
11/1/2025	3:15:00 PM	0
11/1/2025	3:30:00 PM	0
11/1/2025	3:45:00 PM	0
11/1/2025	4:00:00 PM	0
11/1/2025	4:15:00 PM	0
11/1/2025	4:30:00 PM	0
11/1/2025	4:45:00 PM	0
11/1/2025	5:00:00 PM	0
11/1/2025	5:15:00 PM	0
11/1/2025	5:30:00 PM	0
11/1/2025	5:45:00 PM	0
11/1/2025	6:00:00 PM	0
11/1/2025	6:15:00 PM	0
11/1/2025	6:30:00 PM	0
11/1/2025	6:45:00 PM	0
11/1/2025	7:00:00 PM	0
11/1/2025	7:15:00 PM	0
11/1/2025	7:30:00 PM	0
11/1/2025	7:45:00 PM	0
11/1/2025	8:00:00 PM	0
11/1/2025	8:15:00 PM	0
11/1/2025	8:30:00 PM	0
11/1/2025	8:45:00 PM	0
11/1/2025	9:00:00 PM	0
11/1/2025	9:15:00 PM	0
11/1/2025	9:30:00 PM	0
11/1/2025	9:45:00 PM	0
11/1/2025	10:00:00 PM	0
11/1/2025	10:15:00 PM	0
11/1/2025	10:30:00 PM	0
11/1/2025	10:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/1/2025	11:00:00 PM	0
11/1/2025	11:15:00 PM	0
11/1/2025	11:30:00 PM	0
11/1/2025	11:45:00 PM	0
11/2/2025	12:00:00 AM	0
11/2/2025	12:15:00 AM	0
11/2/2025	12:30:00 AM	0
11/2/2025	12:45:00 AM	0
11/2/2025	1:00:00 AM	0
11/2/2025	1:15:00 AM	0
11/2/2025	1:30:00 AM	0
11/2/2025	1:45:00 AM	0
11/2/2025	2:00:00 AM	0
11/2/2025	2:15:00 AM	0
11/2/2025	2:30:00 AM	0
11/2/2025	2:45:00 AM	0
11/2/2025	3:00:00 AM	0
11/2/2025	3:15:00 AM	0
11/2/2025	3:30:00 AM	0
11/2/2025	3:45:00 AM	0
11/2/2025	4:00:00 AM	0
11/2/2025	4:15:00 AM	0
11/2/2025	4:30:00 AM	0
11/2/2025	4:45:00 AM	0
11/2/2025	5:00:00 AM	0
11/2/2025	5:15:00 AM	0
11/2/2025	5:30:00 AM	0
11/2/2025	5:45:00 AM	0
11/2/2025	6:00:00 AM	0
11/2/2025	6:15:00 AM	0
11/2/2025	6:30:00 AM	0
11/2/2025	6:45:00 AM	0
11/2/2025	7:00:00 AM	0
11/2/2025	7:15:00 AM	0
11/2/2025	7:30:00 AM	0
11/2/2025	7:45:00 AM	0
11/2/2025	8:00:00 AM	0
11/2/2025	8:15:00 AM	0
11/2/2025	8:30:00 AM	0
11/2/2025	8:45:00 AM	0
11/2/2025	9:00:00 AM	0
11/2/2025	9:15:00 AM	0
11/2/2025	9:30:00 AM	0
11/2/2025	9:45:00 AM	0
11/2/2025	10:00:00 AM	0
11/2/2025	10:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/2/2025	10:30:00 AM	0
11/2/2025	10:45:00 AM	0
11/2/2025	11:00:00 AM	0
11/2/2025	11:15:00 AM	0
11/2/2025	11:30:00 AM	0
11/2/2025	11:45:00 AM	0
11/2/2025	12:00:00 PM	0
11/2/2025	12:15:00 PM	0
11/2/2025	12:30:00 PM	0
11/2/2025	12:45:00 PM	0
11/2/2025	1:00:00 PM	0
11/2/2025	1:15:00 PM	0
11/2/2025	1:30:00 PM	0
11/2/2025	1:45:00 PM	0
11/2/2025	2:00:00 PM	0
11/2/2025	2:15:00 PM	0
11/2/2025	2:30:00 PM	0
11/2/2025	2:45:00 PM	0
11/2/2025	3:00:00 PM	0
11/2/2025	3:15:00 PM	0
11/2/2025	3:30:00 PM	0
11/2/2025	3:45:00 PM	0
11/2/2025	4:00:00 PM	0
11/2/2025	4:15:00 PM	0
11/2/2025	4:30:00 PM	0
11/2/2025	4:45:00 PM	0
11/2/2025	5:00:00 PM	0
11/2/2025	5:15:00 PM	0
11/2/2025	5:30:00 PM	0
11/2/2025	5:45:00 PM	0
11/2/2025	6:00:00 PM	0
11/2/2025	6:15:00 PM	0
11/2/2025	6:30:00 PM	0
11/2/2025	6:45:00 PM	0
11/2/2025	7:00:00 PM	0
11/2/2025	7:15:00 PM	0
11/2/2025	7:30:00 PM	0
11/2/2025	7:45:00 PM	0
11/2/2025	8:00:00 PM	0
11/2/2025	8:15:00 PM	0
11/2/2025	8:30:00 PM	0
11/2/2025	8:45:00 PM	0
11/2/2025	9:00:00 PM	0
11/2/2025	9:15:00 PM	0
11/2/2025	9:30:00 PM	0
11/2/2025	9:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/2/2025	10:00:00 PM	0
11/2/2025	10:15:00 PM	0
11/2/2025	10:30:00 PM	0
11/2/2025	10:45:00 PM	0
11/2/2025	11:00:00 PM	0
11/2/2025	11:15:00 PM	0
11/2/2025	11:30:00 PM	0
11/2/2025	11:45:00 PM	0
11/3/2025	12:00:00 AM	0
11/3/2025	12:15:00 AM	0
11/3/2025	12:30:00 AM	0
11/3/2025	12:45:00 AM	0
11/3/2025	1:00:00 AM	0
11/3/2025	1:15:00 AM	0
11/3/2025	1:30:00 AM	0
11/3/2025	1:45:00 AM	0
11/3/2025	2:00:00 AM	0
11/3/2025	2:15:00 AM	0
11/3/2025	2:30:00 AM	0
11/3/2025	2:45:00 AM	0
11/3/2025	3:00:00 AM	0
11/3/2025	3:15:00 AM	0
11/3/2025	3:30:00 AM	0
11/3/2025	3:45:00 AM	0
11/3/2025	4:00:00 AM	0
11/3/2025	4:15:00 AM	0
11/3/2025	4:30:00 AM	0
11/3/2025	4:45:00 AM	0
11/3/2025	5:00:00 AM	0
11/3/2025	5:15:00 AM	0
11/3/2025	5:30:00 AM	0
11/3/2025	5:45:00 AM	0
11/3/2025	6:00:00 AM	0
11/3/2025	6:15:00 AM	0
11/3/2025	6:30:00 AM	0
11/3/2025	6:45:00 AM	0
11/3/2025	7:00:00 AM	0
11/3/2025	7:15:00 AM	0
11/3/2025	7:30:00 AM	0
11/3/2025	7:45:00 AM	0
11/3/2025	8:00:00 AM	0
11/3/2025	8:15:00 AM	0
11/3/2025	8:30:00 AM	0
11/3/2025	8:45:00 AM	0
11/3/2025	9:00:00 AM	0
11/3/2025	9:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/3/2025	9:30:00 AM	0
11/3/2025	9:45:00 AM	0
11/3/2025	10:00:00 AM	0
11/3/2025	10:15:00 AM	0
11/3/2025	10:30:00 AM	0
11/3/2025	10:45:00 AM	0
11/3/2025	11:00:00 AM	0
11/3/2025	11:15:00 AM	0
11/3/2025	11:30:00 AM	0
11/3/2025	11:45:00 AM	0
11/3/2025	12:00:00 PM	0
11/3/2025	12:15:00 PM	0
11/3/2025	12:30:00 PM	0
11/3/2025	12:45:00 PM	0
11/3/2025	1:00:00 PM	0
11/3/2025	1:15:00 PM	0
11/3/2025	1:30:00 PM	0
11/3/2025	1:45:00 PM	0
11/3/2025	2:00:00 PM	0
11/3/2025	2:15:00 PM	0
11/3/2025	2:30:00 PM	0
11/3/2025	2:45:00 PM	0
11/3/2025	3:00:00 PM	0
11/3/2025	3:15:00 PM	0
11/3/2025	3:30:00 PM	0
11/3/2025	3:45:00 PM	0
11/3/2025	4:00:00 PM	0
11/3/2025	4:15:00 PM	0
11/3/2025	4:30:00 PM	0
11/3/2025	4:45:00 PM	0
11/3/2025	5:00:00 PM	0
11/3/2025	5:15:00 PM	0
11/3/2025	5:30:00 PM	0
11/3/2025	5:45:00 PM	0
11/3/2025	6:00:00 PM	0
11/3/2025	6:15:00 PM	0
11/3/2025	6:30:00 PM	0
11/3/2025	6:45:00 PM	0
11/3/2025	7:00:00 PM	0
11/3/2025	7:15:00 PM	0
11/3/2025	7:30:00 PM	0
11/3/2025	7:45:00 PM	0
11/3/2025	8:00:00 PM	0
11/3/2025	8:15:00 PM	0
11/3/2025	8:30:00 PM	0
11/3/2025	8:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/3/2025	9:00:00 PM	0
11/3/2025	9:15:00 PM	0
11/3/2025	9:30:00 PM	0
11/3/2025	9:45:00 PM	0
11/3/2025	10:00:00 PM	0
11/3/2025	10:15:00 PM	0
11/3/2025	10:30:00 PM	0
11/3/2025	10:45:00 PM	0
11/3/2025	11:00:00 PM	0
11/3/2025	11:15:00 PM	0
11/3/2025	11:30:00 PM	0
11/3/2025	11:45:00 PM	0
11/4/2025	12:00:00 AM	0
11/4/2025	12:15:00 AM	0
11/4/2025	12:30:00 AM	0
11/4/2025	12:45:00 AM	0
11/4/2025	1:00:00 AM	0
11/4/2025	1:15:00 AM	0
11/4/2025	1:30:00 AM	0
11/4/2025	1:45:00 AM	0
11/4/2025	2:00:00 AM	0
11/4/2025	2:15:00 AM	0
11/4/2025	2:30:00 AM	0
11/4/2025	2:45:00 AM	0
11/4/2025	3:00:00 AM	0
11/4/2025	3:15:00 AM	0
11/4/2025	3:30:00 AM	0
11/4/2025	3:45:00 AM	0
11/4/2025	4:00:00 AM	0
11/4/2025	4:15:00 AM	0
11/4/2025	4:30:00 AM	0
11/4/2025	4:45:00 AM	0
11/4/2025	5:00:00 AM	0
11/4/2025	5:15:00 AM	0
11/4/2025	5:30:00 AM	0
11/4/2025	5:45:00 AM	0
11/4/2025	6:00:00 AM	0
11/4/2025	6:15:00 AM	0
11/4/2025	6:30:00 AM	0
11/4/2025	6:45:00 AM	0
11/4/2025	7:00:00 AM	0
11/4/2025	7:15:00 AM	0
11/4/2025	7:30:00 AM	0
11/4/2025	7:45:00 AM	0
11/4/2025	8:00:00 AM	0
11/4/2025	8:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/4/2025	8:30:00 AM	0
11/4/2025	8:45:00 AM	0
11/4/2025	9:00:00 AM	0
11/4/2025	9:15:00 AM	0
11/4/2025	9:30:00 AM	0
11/4/2025	9:45:00 AM	0
11/4/2025	10:00:00 AM	0
11/4/2025	10:15:00 AM	0
11/4/2025	10:30:00 AM	0
11/4/2025	10:45:00 AM	0
11/4/2025	11:00:00 AM	0
11/4/2025	11:15:00 AM	0
11/4/2025	11:30:00 AM	0
11/4/2025	11:45:00 AM	0
11/4/2025	12:00:00 PM	0
11/4/2025	12:15:00 PM	0
11/4/2025	12:30:00 PM	0
11/4/2025	12:45:00 PM	0
11/4/2025	1:00:00 PM	0
11/4/2025	1:15:00 PM	0
11/4/2025	1:30:00 PM	0
11/4/2025	1:45:00 PM	0
11/4/2025	2:00:00 PM	0
11/4/2025	2:15:00 PM	0
11/4/2025	2:30:00 PM	0
11/4/2025	2:45:00 PM	0
11/4/2025	3:00:00 PM	0
11/4/2025	3:15:00 PM	0
11/4/2025	3:30:00 PM	0
11/4/2025	3:45:00 PM	0
11/4/2025	4:00:00 PM	0
11/4/2025	4:15:00 PM	0
11/4/2025	4:30:00 PM	0
11/4/2025	4:45:00 PM	0
11/4/2025	5:00:00 PM	0
11/4/2025	5:15:00 PM	0
11/4/2025	5:30:00 PM	0
11/4/2025	5:45:00 PM	0
11/4/2025	6:00:00 PM	0
11/4/2025	6:15:00 PM	0
11/4/2025	6:30:00 PM	0
11/4/2025	6:45:00 PM	0
11/4/2025	7:00:00 PM	0
11/4/2025	7:15:00 PM	0
11/4/2025	7:30:00 PM	0
11/4/2025	7:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/4/2025	8:00:00 PM	0
11/4/2025	8:15:00 PM	0
11/4/2025	8:30:00 PM	0
11/4/2025	8:45:00 PM	0
11/4/2025	9:00:00 PM	0
11/4/2025	9:15:00 PM	0
11/4/2025	9:30:00 PM	0
11/4/2025	9:45:00 PM	0
11/4/2025	10:00:00 PM	0
11/4/2025	10:15:00 PM	0
11/4/2025	10:30:00 PM	0
11/4/2025	10:45:00 PM	0
11/4/2025	11:00:00 PM	0
11/4/2025	11:15:00 PM	0
11/4/2025	11:30:00 PM	0
11/4/2025	11:45:00 PM	0
11/5/2025	12:00:00 AM	0
11/5/2025	12:15:00 AM	0
11/5/2025	12:30:00 AM	0
11/5/2025	12:45:00 AM	0
11/5/2025	1:00:00 AM	0
11/5/2025	1:15:00 AM	0
11/5/2025	1:30:00 AM	0
11/5/2025	1:45:00 AM	0
11/5/2025	2:00:00 AM	0
11/5/2025	2:15:00 AM	0
11/5/2025	2:30:00 AM	0
11/5/2025	2:45:00 AM	0
11/5/2025	3:00:00 AM	0
11/5/2025	3:15:00 AM	0
11/5/2025	3:30:00 AM	0
11/5/2025	3:45:00 AM	0
11/5/2025	4:00:00 AM	0
11/5/2025	4:15:00 AM	0
11/5/2025	4:30:00 AM	0
11/5/2025	4:45:00 AM	0
11/5/2025	5:00:00 AM	0
11/5/2025	5:15:00 AM	0
11/5/2025	5:30:00 AM	0
11/5/2025	5:45:00 AM	0
11/5/2025	6:00:00 AM	0
11/5/2025	6:15:00 AM	0
11/5/2025	6:30:00 AM	0
11/5/2025	6:45:00 AM	0
11/5/2025	7:00:00 AM	0
11/5/2025	7:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/5/2025	7:30:00 AM	0
11/5/2025	7:45:00 AM	0
11/5/2025	8:00:00 AM	0
11/5/2025	8:15:00 AM	0
11/5/2025	8:30:00 AM	0
11/5/2025	8:45:00 AM	0
11/5/2025	9:00:00 AM	0
11/5/2025	9:15:00 AM	0
11/5/2025	9:30:00 AM	0
11/5/2025	9:45:00 AM	0
11/5/2025	10:00:00 AM	0
11/5/2025	10:15:00 AM	0
11/5/2025	10:30:00 AM	0
11/5/2025	10:45:00 AM	0
11/5/2025	11:00:00 AM	0
11/5/2025	11:15:00 AM	0
11/5/2025	11:30:00 AM	0
11/5/2025	11:45:00 AM	0
11/5/2025	12:00:00 PM	0
11/5/2025	12:15:00 PM	0
11/5/2025	12:30:00 PM	0
11/5/2025	12:45:00 PM	0
11/5/2025	1:00:00 PM	0
11/5/2025	1:15:00 PM	0
11/5/2025	1:30:00 PM	0
11/5/2025	1:45:00 PM	0
11/5/2025	2:00:00 PM	0
11/5/2025	2:15:00 PM	0
11/5/2025	2:30:00 PM	0
11/5/2025	2:45:00 PM	0
11/5/2025	3:00:00 PM	0
11/5/2025	3:15:00 PM	0
11/5/2025	3:30:00 PM	0
11/5/2025	3:45:00 PM	0
11/5/2025	4:00:00 PM	0
11/5/2025	4:15:00 PM	0
11/5/2025	4:30:00 PM	0
11/5/2025	4:45:00 PM	0
11/5/2025	5:00:00 PM	0
11/5/2025	5:15:00 PM	0
11/5/2025	5:30:00 PM	0
11/5/2025	5:45:00 PM	0
11/5/2025	6:00:00 PM	0
11/5/2025	6:15:00 PM	0
11/5/2025	6:30:00 PM	0
11/5/2025	6:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/5/2025	7:00:00 PM	0
11/5/2025	7:15:00 PM	0
11/5/2025	7:30:00 PM	0
11/5/2025	7:45:00 PM	0
11/5/2025	8:00:00 PM	0
11/5/2025	8:15:00 PM	0
11/5/2025	8:30:00 PM	0
11/5/2025	8:45:00 PM	0
11/5/2025	9:00:00 PM	0
11/5/2025	9:15:00 PM	0
11/5/2025	9:30:00 PM	0
11/5/2025	9:45:00 PM	0
11/5/2025	10:00:00 PM	0
11/5/2025	10:15:00 PM	0
11/5/2025	10:30:00 PM	0
11/5/2025	10:45:00 PM	0
11/5/2025	11:00:00 PM	0
11/5/2025	11:15:00 PM	0
11/5/2025	11:30:00 PM	0
11/5/2025	11:45:00 PM	0
11/6/2025	12:00:00 AM	0
11/6/2025	12:15:00 AM	0
11/6/2025	12:30:00 AM	0
11/6/2025	12:45:00 AM	0
11/6/2025	1:00:00 AM	0
11/6/2025	1:15:00 AM	0
11/6/2025	1:30:00 AM	0
11/6/2025	1:45:00 AM	0
11/6/2025	2:00:00 AM	0
11/6/2025	2:15:00 AM	0
11/6/2025	2:30:00 AM	0
11/6/2025	2:45:00 AM	0
11/6/2025	3:00:00 AM	0
11/6/2025	3:15:00 AM	0
11/6/2025	3:30:00 AM	0
11/6/2025	3:45:00 AM	0
11/6/2025	4:00:00 AM	0
11/6/2025	4:15:00 AM	0
11/6/2025	4:30:00 AM	0
11/6/2025	4:45:00 AM	0
11/6/2025	5:00:00 AM	0
11/6/2025	5:15:00 AM	0
11/6/2025	5:30:00 AM	0
11/6/2025	5:45:00 AM	0
11/6/2025	6:00:00 AM	0
11/6/2025	6:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/6/2025	6:30:00 AM	0
11/6/2025	6:45:00 AM	0
11/6/2025	7:00:00 AM	0
11/6/2025	7:15:00 AM	0
11/6/2025	7:30:00 AM	0
11/6/2025	7:45:00 AM	0
11/6/2025	8:00:00 AM	0
11/6/2025	8:15:00 AM	0
11/6/2025	8:30:00 AM	0
11/6/2025	8:45:00 AM	0
11/6/2025	9:00:00 AM	0
11/6/2025	9:15:00 AM	0
11/6/2025	9:30:00 AM	0
11/6/2025	9:45:00 AM	0
11/6/2025	10:00:00 AM	0
11/6/2025	10:15:00 AM	0
11/6/2025	10:30:00 AM	0
11/6/2025	10:45:00 AM	0
11/6/2025	11:00:00 AM	0
11/6/2025	11:15:00 AM	0
11/6/2025	11:30:00 AM	0
11/6/2025	11:45:00 AM	0
11/6/2025	12:00:00 PM	0
11/6/2025	12:15:00 PM	0
11/6/2025	12:30:00 PM	0
11/6/2025	12:45:00 PM	0
11/6/2025	1:00:00 PM	0
11/6/2025	1:15:00 PM	0
11/6/2025	1:30:00 PM	0
11/6/2025	1:45:00 PM	0
11/6/2025	2:00:00 PM	0
11/6/2025	2:15:00 PM	0
11/6/2025	2:30:00 PM	0
11/6/2025	2:45:00 PM	0
11/6/2025	3:00:00 PM	0
11/6/2025	3:15:00 PM	0
11/6/2025	3:30:00 PM	0
11/6/2025	3:45:00 PM	0
11/6/2025	4:00:00 PM	0
11/6/2025	4:15:00 PM	0
11/6/2025	4:30:00 PM	0
11/6/2025	4:45:00 PM	0
11/6/2025	5:00:00 PM	0
11/6/2025	5:15:00 PM	0
11/6/2025	5:30:00 PM	0
11/6/2025	5:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/6/2025	6:00:00 PM	0
11/6/2025	6:15:00 PM	0
11/6/2025	6:30:00 PM	0
11/6/2025	6:45:00 PM	0
11/6/2025	7:00:00 PM	0
11/6/2025	7:15:00 PM	0
11/6/2025	7:30:00 PM	0
11/6/2025	7:45:00 PM	0
11/6/2025	8:00:00 PM	0
11/6/2025	8:15:00 PM	0
11/6/2025	8:30:00 PM	0
11/6/2025	8:45:00 PM	0
11/6/2025	9:00:00 PM	0
11/6/2025	9:15:00 PM	0
11/6/2025	9:30:00 PM	0
11/6/2025	9:45:00 PM	0
11/6/2025	10:00:00 PM	0
11/6/2025	10:15:00 PM	0
11/6/2025	10:30:00 PM	0
11/6/2025	10:45:00 PM	0
11/6/2025	11:00:00 PM	0
11/6/2025	11:15:00 PM	0
11/6/2025	11:30:00 PM	0
11/6/2025	11:45:00 PM	0
11/7/2025	12:00:00 AM	0
11/7/2025	12:15:00 AM	0
11/7/2025	12:30:00 AM	0
11/7/2025	12:45:00 AM	0
11/7/2025	1:00:00 AM	0
11/7/2025	1:15:00 AM	0
11/7/2025	1:30:00 AM	0
11/7/2025	1:45:00 AM	0
11/7/2025	2:00:00 AM	0
11/7/2025	2:15:00 AM	0
11/7/2025	2:30:00 AM	0
11/7/2025	2:45:00 AM	0
11/7/2025	3:00:00 AM	0
11/7/2025	3:15:00 AM	0
11/7/2025	3:30:00 AM	0
11/7/2025	3:45:00 AM	0
11/7/2025	4:00:00 AM	0
11/7/2025	4:15:00 AM	0
11/7/2025	4:30:00 AM	0
11/7/2025	4:45:00 AM	0
11/7/2025	5:00:00 AM	0
11/7/2025	5:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/7/2025	5:30:00 AM	0
11/7/2025	5:45:00 AM	0
11/7/2025	6:00:00 AM	0
11/7/2025	6:15:00 AM	0
11/7/2025	6:30:00 AM	0
11/7/2025	6:45:00 AM	0
11/7/2025	7:00:00 AM	0
11/7/2025	7:15:00 AM	0
11/7/2025	7:30:00 AM	0
11/7/2025	7:45:00 AM	0
11/7/2025	8:00:00 AM	0
11/7/2025	8:15:00 AM	0
11/7/2025	8:30:00 AM	0
11/7/2025	8:45:00 AM	0
11/7/2025	9:00:00 AM	0
11/7/2025	9:15:00 AM	0
11/7/2025	9:30:00 AM	0
11/7/2025	9:45:00 AM	0
11/7/2025	10:00:00 AM	0
11/7/2025	10:15:00 AM	0
11/7/2025	10:30:00 AM	0
11/7/2025	10:45:00 AM	0
11/7/2025	11:00:00 AM	0
11/7/2025	11:15:00 AM	0
11/7/2025	11:30:00 AM	0
11/7/2025	11:45:00 AM	0
11/7/2025	12:00:00 PM	0
11/7/2025	12:15:00 PM	0
11/7/2025	12:30:00 PM	0
11/7/2025	12:45:00 PM	0
11/7/2025	1:00:00 PM	0
11/7/2025	1:15:00 PM	0
11/7/2025	1:30:00 PM	0
11/7/2025	1:45:00 PM	0
11/7/2025	2:00:00 PM	0
11/7/2025	2:15:00 PM	0
11/7/2025	2:30:00 PM	0
11/7/2025	2:45:00 PM	0
11/7/2025	3:00:00 PM	0
11/7/2025	3:15:00 PM	0
11/7/2025	3:30:00 PM	0
11/7/2025	3:45:00 PM	0
11/7/2025	4:00:00 PM	0
11/7/2025	4:15:00 PM	0
11/7/2025	4:30:00 PM	0
11/7/2025	4:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/7/2025	5:00:00 PM	0
11/7/2025	5:15:00 PM	0
11/7/2025	5:30:00 PM	0
11/7/2025	5:45:00 PM	0
11/7/2025	6:00:00 PM	0
11/7/2025	6:15:00 PM	0
11/7/2025	6:30:00 PM	0
11/7/2025	6:45:00 PM	0
11/7/2025	7:00:00 PM	0
11/7/2025	7:15:00 PM	0
11/7/2025	7:30:00 PM	0
11/7/2025	7:45:00 PM	0
11/7/2025	8:00:00 PM	0
11/7/2025	8:15:00 PM	0
11/7/2025	8:30:00 PM	0
11/7/2025	8:45:00 PM	0
11/7/2025	9:00:00 PM	0
11/7/2025	9:15:00 PM	0
11/7/2025	9:30:00 PM	0
11/7/2025	9:45:00 PM	0
11/7/2025	10:00:00 PM	0
11/7/2025	10:15:00 PM	0
11/7/2025	10:30:00 PM	0
11/7/2025	10:45:00 PM	0
11/7/2025	11:00:00 PM	0
11/7/2025	11:15:00 PM	0
11/7/2025	11:30:00 PM	0
11/7/2025	11:45:00 PM	0
11/8/2025	12:00:00 AM	0
11/8/2025	12:15:00 AM	0
11/8/2025	12:30:00 AM	0
11/8/2025	12:45:00 AM	0
11/8/2025	1:00:00 AM	0
11/8/2025	1:15:00 AM	0
11/8/2025	1:30:00 AM	0
11/8/2025	1:45:00 AM	0
11/8/2025	2:00:00 AM	0
11/8/2025	2:15:00 AM	0
11/8/2025	2:30:00 AM	0
11/8/2025	2:45:00 AM	0
11/8/2025	3:00:00 AM	0
11/8/2025	3:15:00 AM	0
11/8/2025	3:30:00 AM	0
11/8/2025	3:45:00 AM	0
11/8/2025	4:00:00 AM	0
11/8/2025	4:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/8/2025	4:30:00 AM	0
11/8/2025	4:45:00 AM	0
11/8/2025	5:00:00 AM	0
11/8/2025	5:15:00 AM	0
11/8/2025	5:30:00 AM	0
11/8/2025	5:45:00 AM	0
11/8/2025	6:00:00 AM	0
11/8/2025	6:15:00 AM	0
11/8/2025	6:30:00 AM	0
11/8/2025	6:45:00 AM	0
11/8/2025	7:00:00 AM	0
11/8/2025	7:15:00 AM	0
11/8/2025	7:30:00 AM	0
11/8/2025	7:45:00 AM	0
11/8/2025	8:00:00 AM	0
11/8/2025	8:15:00 AM	0
11/8/2025	8:30:00 AM	0
11/8/2025	8:45:00 AM	0
11/8/2025	9:00:00 AM	0
11/8/2025	9:15:00 AM	0
11/8/2025	9:30:00 AM	0
11/8/2025	9:45:00 AM	0
11/8/2025	10:00:00 AM	0
11/8/2025	10:15:00 AM	0
11/8/2025	10:30:00 AM	0
11/8/2025	10:45:00 AM	0
11/8/2025	11:00:00 AM	0
11/8/2025	11:15:00 AM	0
11/8/2025	11:30:00 AM	0
11/8/2025	11:45:00 AM	0
11/8/2025	12:00:00 PM	0
11/8/2025	12:15:00 PM	0
11/8/2025	12:30:00 PM	0
11/8/2025	12:45:00 PM	0
11/8/2025	1:00:00 PM	0
11/8/2025	1:15:00 PM	0
11/8/2025	1:30:00 PM	0
11/8/2025	1:45:00 PM	0
11/8/2025	2:00:00 PM	0
11/8/2025	2:15:00 PM	0
11/8/2025	2:30:00 PM	0
11/8/2025	2:45:00 PM	0
11/8/2025	3:00:00 PM	0
11/8/2025	3:15:00 PM	0
11/8/2025	3:30:00 PM	0
11/8/2025	3:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/8/2025	4:00:00 PM	0
11/8/2025	4:15:00 PM	0
11/8/2025	4:30:00 PM	0
11/8/2025	4:45:00 PM	0
11/8/2025	5:00:00 PM	0
11/8/2025	5:15:00 PM	0
11/8/2025	5:30:00 PM	0
11/8/2025	5:45:00 PM	0
11/8/2025	6:00:00 PM	0
11/8/2025	6:15:00 PM	0
11/8/2025	6:30:00 PM	0
11/8/2025	6:45:00 PM	0
11/8/2025	7:00:00 PM	0
11/8/2025	7:15:00 PM	0
11/8/2025	7:30:00 PM	0
11/8/2025	7:45:00 PM	0
11/8/2025	8:00:00 PM	0
11/8/2025	8:15:00 PM	0
11/8/2025	8:30:00 PM	0
11/8/2025	8:45:00 PM	0
11/8/2025	9:00:00 PM	0
11/8/2025	9:15:00 PM	0
11/8/2025	9:30:00 PM	0
11/8/2025	9:45:00 PM	0
11/8/2025	10:00:00 PM	0
11/8/2025	10:15:00 PM	0
11/8/2025	10:30:00 PM	0
11/8/2025	10:45:00 PM	0
11/8/2025	11:00:00 PM	0
11/8/2025	11:15:00 PM	0
11/8/2025	11:30:00 PM	0
11/8/2025	11:45:00 PM	0
11/9/2025	12:00:00 AM	0
11/9/2025	12:15:00 AM	0
11/9/2025	12:30:00 AM	0
11/9/2025	12:45:00 AM	0
11/9/2025	1:00:00 AM	0
11/9/2025	1:15:00 AM	0
11/9/2025	1:30:00 AM	0
11/9/2025	1:45:00 AM	0
11/9/2025	2:00:00 AM	0
11/9/2025	2:15:00 AM	0
11/9/2025	2:30:00 AM	0
11/9/2025	2:45:00 AM	0
11/9/2025	3:00:00 AM	0
11/9/2025	3:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/9/2025	3:30:00 AM	0
11/9/2025	3:45:00 AM	0
11/9/2025	4:00:00 AM	0
11/9/2025	4:15:00 AM	0
11/9/2025	4:30:00 AM	0
11/9/2025	4:45:00 AM	0
11/9/2025	5:00:00 AM	0
11/9/2025	5:15:00 AM	0
11/9/2025	5:30:00 AM	0
11/9/2025	5:45:00 AM	0
11/9/2025	6:00:00 AM	0
11/9/2025	6:15:00 AM	0
11/9/2025	6:30:00 AM	0
11/9/2025	6:45:00 AM	0
11/9/2025	7:00:00 AM	0
11/9/2025	7:15:00 AM	0
11/9/2025	7:30:00 AM	0
11/9/2025	7:45:00 AM	0
11/9/2025	8:00:00 AM	0
11/9/2025	8:15:00 AM	0
11/9/2025	8:30:00 AM	0
11/9/2025	8:45:00 AM	0
11/9/2025	9:00:00 AM	0
11/9/2025	9:15:00 AM	0
11/9/2025	9:30:00 AM	0
11/9/2025	9:45:00 AM	0
11/9/2025	10:00:00 AM	0
11/9/2025	10:15:00 AM	0
11/9/2025	10:30:00 AM	0
11/9/2025	10:45:00 AM	0
11/9/2025	11:00:00 AM	0
11/9/2025	11:15:00 AM	0
11/9/2025	11:30:00 AM	0
11/9/2025	11:45:00 AM	0
11/9/2025	12:00:00 PM	0
11/9/2025	12:15:00 PM	0
11/9/2025	12:30:00 PM	0
11/9/2025	12:45:00 PM	0
11/9/2025	1:00:00 PM	0
11/9/2025	1:15:00 PM	0
11/9/2025	1:30:00 PM	0
11/9/2025	1:45:00 PM	0
11/9/2025	2:00:00 PM	0
11/9/2025	2:15:00 PM	0
11/9/2025	2:30:00 PM	0
11/9/2025	2:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/9/2025	3:00:00 PM	0
11/9/2025	3:15:00 PM	0
11/9/2025	3:30:00 PM	0
11/9/2025	3:45:00 PM	0
11/9/2025	4:00:00 PM	0
11/9/2025	4:15:00 PM	0
11/9/2025	4:30:00 PM	0
11/9/2025	4:45:00 PM	0
11/9/2025	5:00:00 PM	0
11/9/2025	5:15:00 PM	0
11/9/2025	5:30:00 PM	0
11/9/2025	5:45:00 PM	0
11/9/2025	6:00:00 PM	0
11/9/2025	6:15:00 PM	0
11/9/2025	6:30:00 PM	0
11/9/2025	6:45:00 PM	0
11/9/2025	7:00:00 PM	0
11/9/2025	7:15:00 PM	0
11/9/2025	7:30:00 PM	0
11/9/2025	7:45:00 PM	0
11/9/2025	8:00:00 PM	0
11/9/2025	8:15:00 PM	0
11/9/2025	8:30:00 PM	0
11/9/2025	8:45:00 PM	0
11/9/2025	9:00:00 PM	0
11/9/2025	9:15:00 PM	0
11/9/2025	9:30:00 PM	0
11/9/2025	9:45:00 PM	0
11/9/2025	10:00:00 PM	0
11/9/2025	10:15:00 PM	0
11/9/2025	10:30:00 PM	0
11/9/2025	10:45:00 PM	0
11/9/2025	11:00:00 PM	0
11/9/2025	11:15:00 PM	0
11/9/2025	11:30:00 PM	0
11/9/2025	11:45:00 PM	0
11/10/2025	12:00:00 AM	0
11/10/2025	12:15:00 AM	0
11/10/2025	12:30:00 AM	0
11/10/2025	12:45:00 AM	0
11/10/2025	1:00:00 AM	0
11/10/2025	1:15:00 AM	0
11/10/2025	1:30:00 AM	0
11/10/2025	1:45:00 AM	0
11/10/2025	2:00:00 AM	0
11/10/2025	2:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/10/2025	2:30:00 AM	0
11/10/2025	2:45:00 AM	0
11/10/2025	3:00:00 AM	0
11/10/2025	3:15:00 AM	0
11/10/2025	3:30:00 AM	0
11/10/2025	3:45:00 AM	0
11/10/2025	4:00:00 AM	0
11/10/2025	4:15:00 AM	0
11/10/2025	4:30:00 AM	0
11/10/2025	4:45:00 AM	0
11/10/2025	5:00:00 AM	0
11/10/2025	5:15:00 AM	0
11/10/2025	5:30:00 AM	0
11/10/2025	5:45:00 AM	0
11/10/2025	6:00:00 AM	0
11/10/2025	6:15:00 AM	0
11/10/2025	6:30:00 AM	0
11/10/2025	6:45:00 AM	0
11/10/2025	7:00:00 AM	0
11/10/2025	7:15:00 AM	0
11/10/2025	7:30:00 AM	0
11/10/2025	7:45:00 AM	0
11/10/2025	8:00:00 AM	0
11/10/2025	8:15:00 AM	0
11/10/2025	8:30:00 AM	0
11/10/2025	8:45:00 AM	0
11/10/2025	9:00:00 AM	0
11/10/2025	9:15:00 AM	0
11/10/2025	9:30:00 AM	0
11/10/2025	9:45:00 AM	0
11/10/2025	10:00:00 AM	0
11/10/2025	10:15:00 AM	0
11/10/2025	10:30:00 AM	0
11/10/2025	10:45:00 AM	0
11/10/2025	11:00:00 AM	0
11/10/2025	11:15:00 AM	0
11/10/2025	11:30:00 AM	0
11/10/2025	11:45:00 AM	0
11/10/2025	12:00:00 PM	0
11/10/2025	12:15:00 PM	0
11/10/2025	12:30:00 PM	0
11/10/2025	12:45:00 PM	0
11/10/2025	1:00:00 PM	0
11/10/2025	1:15:00 PM	0
11/10/2025	1:30:00 PM	0
11/10/2025	1:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/10/2025	2:00:00 PM	0
11/10/2025	2:15:00 PM	0
11/10/2025	2:30:00 PM	0
11/10/2025	2:45:00 PM	0
11/10/2025	3:00:00 PM	0
11/10/2025	3:15:00 PM	0
11/10/2025	3:30:00 PM	0
11/10/2025	3:45:00 PM	0
11/10/2025	4:00:00 PM	0
11/10/2025	4:15:00 PM	0
11/10/2025	4:30:00 PM	0
11/10/2025	4:45:00 PM	0
11/10/2025	5:00:00 PM	0
11/10/2025	5:15:00 PM	0
11/10/2025	5:30:00 PM	0
11/10/2025	5:45:00 PM	0
11/10/2025	6:00:00 PM	0
11/10/2025	6:15:00 PM	0
11/10/2025	6:30:00 PM	0
11/10/2025	6:45:00 PM	0
11/10/2025	7:00:00 PM	0
11/10/2025	7:15:00 PM	0
11/10/2025	7:30:00 PM	0
11/10/2025	7:45:00 PM	0
11/10/2025	8:00:00 PM	0
11/10/2025	8:15:00 PM	0
11/10/2025	8:30:00 PM	0
11/10/2025	8:45:00 PM	0
11/10/2025	9:00:00 PM	0
11/10/2025	9:15:00 PM	0
11/10/2025	9:30:00 PM	0
11/10/2025	9:45:00 PM	0
11/10/2025	10:00:00 PM	0
11/10/2025	10:15:00 PM	0
11/10/2025	10:30:00 PM	0
11/10/2025	10:45:00 PM	0
11/10/2025	11:00:00 PM	0
11/10/2025	11:15:00 PM	0
11/10/2025	11:30:00 PM	0
11/10/2025	11:45:00 PM	0
11/11/2025	12:00:00 AM	0
11/11/2025	12:15:00 AM	0
11/11/2025	12:30:00 AM	0
11/11/2025	12:45:00 AM	0
11/11/2025	1:00:00 AM	0
11/11/2025	1:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/11/2025	1:30:00 AM	0
11/11/2025	1:45:00 AM	0
11/11/2025	2:00:00 AM	0
11/11/2025	2:15:00 AM	0
11/11/2025	2:30:00 AM	0
11/11/2025	2:45:00 AM	0
11/11/2025	3:00:00 AM	0
11/11/2025	3:15:00 AM	0
11/11/2025	3:30:00 AM	0
11/11/2025	3:45:00 AM	0
11/11/2025	4:00:00 AM	0
11/11/2025	4:15:00 AM	0
11/11/2025	4:30:00 AM	0
11/11/2025	4:45:00 AM	0
11/11/2025	5:00:00 AM	0
11/11/2025	5:15:00 AM	0
11/11/2025	5:30:00 AM	0
11/11/2025	5:45:00 AM	0
11/11/2025	6:00:00 AM	0
11/11/2025	6:15:00 AM	0
11/11/2025	6:30:00 AM	0
11/11/2025	6:45:00 AM	0
11/11/2025	7:00:00 AM	0
11/11/2025	7:15:00 AM	0
11/11/2025	7:30:00 AM	0
11/11/2025	7:45:00 AM	0
11/11/2025	8:00:00 AM	0
11/11/2025	8:15:00 AM	0
11/11/2025	8:30:00 AM	0
11/11/2025	8:45:00 AM	0
11/11/2025	9:00:00 AM	0
11/11/2025	9:15:00 AM	0
11/11/2025	9:30:00 AM	0
11/11/2025	9:45:00 AM	0
11/11/2025	10:00:00 AM	0
11/11/2025	10:15:00 AM	0
11/11/2025	10:30:00 AM	0
11/11/2025	10:45:00 AM	0
11/11/2025	11:00:00 AM	0
11/11/2025	11:15:00 AM	0
11/11/2025	11:30:00 AM	0
11/11/2025	11:45:00 AM	0
11/11/2025	12:00:00 PM	0
11/11/2025	12:15:00 PM	0
11/11/2025	12:30:00 PM	0
11/11/2025	12:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/11/2025	1:00:00 PM	0
11/11/2025	1:15:00 PM	0
11/11/2025	1:30:00 PM	0
11/11/2025	1:45:00 PM	0
11/11/2025	2:00:00 PM	0
11/11/2025	2:15:00 PM	0
11/11/2025	2:30:00 PM	0
11/11/2025	2:45:00 PM	0
11/11/2025	3:00:00 PM	0
11/11/2025	3:15:00 PM	0
11/11/2025	3:30:00 PM	0
11/11/2025	3:45:00 PM	0
11/11/2025	4:00:00 PM	0
11/11/2025	4:15:00 PM	0
11/11/2025	4:30:00 PM	0
11/11/2025	4:45:00 PM	0
11/11/2025	5:00:00 PM	0
11/11/2025	5:15:00 PM	0
11/11/2025	5:30:00 PM	0
11/11/2025	5:45:00 PM	0
11/11/2025	6:00:00 PM	0
11/11/2025	6:15:00 PM	0
11/11/2025	6:30:00 PM	0
11/11/2025	6:45:00 PM	0
11/11/2025	7:00:00 PM	0
11/11/2025	7:15:00 PM	0
11/11/2025	7:30:00 PM	0
11/11/2025	7:45:00 PM	0
11/11/2025	8:00:00 PM	0
11/11/2025	8:15:00 PM	0
11/11/2025	8:30:00 PM	0
11/11/2025	8:45:00 PM	0
11/11/2025	9:00:00 PM	0
11/11/2025	9:15:00 PM	0
11/11/2025	9:30:00 PM	0
11/11/2025	9:45:00 PM	0
11/11/2025	10:00:00 PM	0
11/11/2025	10:15:00 PM	0
11/11/2025	10:30:00 PM	0
11/11/2025	10:45:00 PM	0
11/11/2025	11:00:00 PM	0
11/11/2025	11:15:00 PM	0
11/11/2025	11:30:00 PM	0
11/11/2025	11:45:00 PM	0
11/12/2025	12:00:00 AM	0
11/12/2025	12:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/12/2025	12:30:00 AM	0
11/12/2025	12:45:00 AM	0
11/12/2025	1:00:00 AM	0
11/12/2025	1:15:00 AM	0
11/12/2025	1:30:00 AM	0
11/12/2025	1:45:00 AM	0
11/12/2025	2:00:00 AM	0
11/12/2025	2:15:00 AM	0
11/12/2025	2:30:00 AM	0
11/12/2025	2:45:00 AM	0
11/12/2025	3:00:00 AM	0
11/12/2025	3:15:00 AM	0
11/12/2025	3:30:00 AM	0
11/12/2025	3:45:00 AM	0
11/12/2025	4:00:00 AM	0
11/12/2025	4:15:00 AM	0
11/12/2025	4:30:00 AM	0
11/12/2025	4:45:00 AM	0
11/12/2025	5:00:00 AM	0
11/12/2025	5:15:00 AM	0
11/12/2025	5:30:00 AM	0
11/12/2025	5:45:00 AM	0
11/12/2025	6:00:00 AM	0
11/12/2025	6:15:00 AM	0
11/12/2025	6:30:00 AM	0
11/12/2025	6:45:00 AM	0
11/12/2025	7:00:00 AM	0
11/12/2025	7:15:00 AM	0
11/12/2025	7:30:00 AM	0
11/12/2025	7:45:00 AM	0
11/12/2025	8:00:00 AM	0
11/12/2025	8:15:00 AM	0
11/12/2025	8:30:00 AM	0
11/12/2025	8:45:00 AM	0
11/12/2025	9:00:00 AM	0
11/12/2025	9:15:00 AM	0
11/12/2025	9:30:00 AM	0
11/12/2025	9:45:00 AM	0
11/12/2025	10:00:00 AM	0
11/12/2025	10:15:00 AM	0
11/12/2025	10:30:00 AM	0
11/12/2025	10:45:00 AM	0
11/12/2025	11:00:00 AM	0
11/12/2025	11:15:00 AM	0
11/12/2025	11:30:00 AM	0
11/12/2025	11:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/12/2025	12:00:00 PM	0
11/12/2025	12:15:00 PM	0
11/12/2025	12:30:00 PM	0
11/12/2025	12:45:00 PM	0
11/12/2025	1:00:00 PM	0
11/12/2025	1:15:00 PM	0
11/12/2025	1:30:00 PM	0
11/12/2025	1:45:00 PM	0
11/12/2025	2:00:00 PM	0
11/12/2025	2:15:00 PM	0
11/12/2025	2:30:00 PM	0
11/12/2025	2:45:00 PM	0
11/12/2025	3:00:00 PM	0
11/12/2025	3:15:00 PM	0
11/12/2025	3:30:00 PM	0
11/12/2025	3:45:00 PM	0
11/12/2025	4:00:00 PM	0
11/12/2025	4:15:00 PM	0
11/12/2025	4:30:00 PM	0
11/12/2025	4:45:00 PM	0
11/12/2025	5:00:00 PM	0
11/12/2025	5:15:00 PM	0
11/12/2025	5:30:00 PM	0
11/12/2025	5:45:00 PM	0
11/12/2025	6:00:00 PM	0
11/12/2025	6:15:00 PM	0
11/12/2025	6:30:00 PM	0
11/12/2025	6:45:00 PM	0
11/12/2025	7:00:00 PM	0
11/12/2025	7:15:00 PM	0
11/12/2025	7:30:00 PM	0
11/12/2025	7:45:00 PM	0
11/12/2025	8:00:00 PM	0
11/12/2025	8:15:00 PM	0
11/12/2025	8:30:00 PM	0
11/12/2025	8:45:00 PM	0
11/12/2025	9:00:00 PM	0
11/12/2025	9:15:00 PM	0
11/12/2025	9:30:00 PM	0
11/12/2025	9:45:00 PM	0
11/12/2025	10:00:00 PM	0
11/12/2025	10:15:00 PM	0
11/12/2025	10:30:00 PM	0
11/12/2025	10:45:00 PM	0
11/12/2025	11:00:00 PM	0
11/12/2025	11:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/12/2025	11:30:00 PM	0
11/12/2025	11:45:00 PM	0
11/13/2025	12:00:00 AM	0
11/13/2025	12:15:00 AM	0
11/13/2025	12:30:00 AM	0
11/13/2025	12:45:00 AM	0
11/13/2025	1:00:00 AM	0
11/13/2025	1:15:00 AM	0
11/13/2025	1:30:00 AM	0
11/13/2025	1:45:00 AM	0
11/13/2025	2:00:00 AM	0
11/13/2025	2:15:00 AM	0
11/13/2025	2:30:00 AM	0
11/13/2025	2:45:00 AM	0
11/13/2025	3:00:00 AM	0
11/13/2025	3:15:00 AM	0
11/13/2025	3:30:00 AM	0
11/13/2025	3:45:00 AM	0
11/13/2025	4:00:00 AM	0
11/13/2025	4:15:00 AM	0
11/13/2025	4:30:00 AM	0
11/13/2025	4:45:00 AM	0
11/13/2025	5:00:00 AM	0
11/13/2025	5:15:00 AM	0
11/13/2025	5:30:00 AM	0
11/13/2025	5:45:00 AM	0
11/13/2025	6:00:00 AM	0
11/13/2025	6:15:00 AM	0
11/13/2025	6:30:00 AM	0
11/13/2025	6:45:00 AM	0
11/13/2025	7:00:00 AM	0
11/13/2025	7:15:00 AM	0
11/13/2025	7:30:00 AM	0
11/13/2025	7:45:00 AM	0
11/13/2025	8:00:00 AM	0
11/13/2025	8:15:00 AM	0
11/13/2025	8:30:00 AM	0
11/13/2025	8:45:00 AM	0
11/13/2025	9:00:00 AM	0
11/13/2025	9:15:00 AM	0
11/13/2025	9:30:00 AM	0
11/13/2025	9:45:00 AM	0
11/13/2025	10:00:00 AM	0
11/13/2025	10:15:00 AM	0
11/13/2025	10:30:00 AM	0
11/13/2025	10:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/13/2025	11:00:00 AM	0
11/13/2025	11:15:00 AM	0
11/13/2025	11:30:00 AM	0
11/13/2025	11:45:00 AM	0
11/13/2025	12:00:00 PM	0
11/13/2025	12:15:00 PM	0
11/13/2025	12:30:00 PM	0
11/13/2025	12:45:00 PM	0
11/13/2025	1:00:00 PM	0
11/13/2025	1:15:00 PM	0
11/13/2025	1:30:00 PM	0
11/13/2025	1:45:00 PM	0
11/13/2025	2:00:00 PM	0
11/13/2025	2:15:00 PM	0
11/13/2025	2:30:00 PM	0
11/13/2025	2:45:00 PM	0
11/13/2025	3:00:00 PM	0
11/13/2025	3:15:00 PM	0
11/13/2025	3:30:00 PM	0
11/13/2025	3:45:00 PM	0
11/13/2025	4:00:00 PM	0
11/13/2025	4:15:00 PM	0
11/13/2025	4:30:00 PM	0
11/13/2025	4:45:00 PM	0
11/13/2025	5:00:00 PM	0
11/13/2025	5:15:00 PM	0
11/13/2025	5:30:00 PM	0
11/13/2025	5:45:00 PM	0
11/13/2025	6:00:00 PM	0
11/13/2025	6:15:00 PM	0
11/13/2025	6:30:00 PM	0
11/13/2025	6:45:00 PM	0
11/13/2025	7:00:00 PM	0
11/13/2025	7:15:00 PM	0
11/13/2025	7:30:00 PM	0
11/13/2025	7:45:00 PM	0
11/13/2025	8:00:00 PM	0
11/13/2025	8:15:00 PM	0
11/13/2025	8:30:00 PM	0
11/13/2025	8:45:00 PM	0
11/13/2025	9:00:00 PM	0
11/13/2025	9:15:00 PM	0
11/13/2025	9:30:00 PM	0
11/13/2025	9:45:00 PM	0
11/13/2025	10:00:00 PM	0
11/13/2025	10:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/13/2025	10:30:00 PM	0
11/13/2025	10:45:00 PM	0
11/13/2025	11:00:00 PM	0
11/13/2025	11:15:00 PM	0
11/13/2025	11:30:00 PM	0
11/13/2025	11:45:00 PM	0
11/14/2025	12:00:00 AM	0
11/14/2025	12:15:00 AM	0
11/14/2025	12:30:00 AM	0
11/14/2025	12:45:00 AM	0
11/14/2025	1:00:00 AM	0
11/14/2025	1:15:00 AM	0
11/14/2025	1:30:00 AM	0
11/14/2025	1:45:00 AM	0
11/14/2025	2:00:00 AM	0
11/14/2025	2:15:00 AM	0
11/14/2025	2:30:00 AM	0
11/14/2025	2:45:00 AM	0
11/14/2025	3:00:00 AM	0
11/14/2025	3:15:00 AM	0
11/14/2025	3:30:00 AM	0
11/14/2025	3:45:00 AM	0
11/14/2025	4:00:00 AM	0
11/14/2025	4:15:00 AM	0
11/14/2025	4:30:00 AM	0
11/14/2025	4:45:00 AM	0
11/14/2025	5:00:00 AM	0
11/14/2025	5:15:00 AM	0
11/14/2025	5:30:00 AM	0
11/14/2025	5:45:00 AM	0
11/14/2025	6:00:00 AM	0
11/14/2025	6:15:00 AM	0
11/14/2025	6:30:00 AM	0
11/14/2025	6:45:00 AM	0
11/14/2025	7:00:00 AM	0
11/14/2025	7:15:00 AM	0
11/14/2025	7:30:00 AM	0
11/14/2025	7:45:00 AM	0
11/14/2025	8:00:00 AM	0
11/14/2025	8:15:00 AM	0
11/14/2025	8:30:00 AM	0
11/14/2025	8:45:00 AM	0
11/14/2025	9:00:00 AM	0
11/14/2025	9:15:00 AM	0
11/14/2025	9:30:00 AM	0
11/14/2025	9:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/14/2025	10:00:00 AM	0
11/14/2025	10:15:00 AM	0
11/14/2025	10:30:00 AM	0
11/14/2025	10:45:00 AM	0
11/14/2025	11:00:00 AM	0
11/14/2025	11:15:00 AM	0
11/14/2025	11:30:00 AM	0
11/14/2025	11:45:00 AM	0
11/14/2025	12:00:00 PM	0
11/14/2025	12:15:00 PM	0
11/14/2025	12:30:00 PM	0
11/14/2025	12:45:00 PM	0
11/14/2025	1:00:00 PM	0
11/14/2025	1:15:00 PM	0
11/14/2025	1:30:00 PM	0
11/14/2025	1:45:00 PM	0
11/14/2025	2:00:00 PM	0
11/14/2025	2:15:00 PM	0
11/14/2025	2:30:00 PM	0
11/14/2025	2:45:00 PM	0
11/14/2025	3:00:00 PM	0
11/14/2025	3:15:00 PM	0
11/14/2025	3:30:00 PM	0
11/14/2025	3:45:00 PM	0
11/14/2025	4:00:00 PM	0
11/14/2025	4:15:00 PM	0
11/14/2025	4:30:00 PM	0
11/14/2025	4:45:00 PM	0
11/14/2025	5:00:00 PM	0
11/14/2025	5:15:00 PM	0
11/14/2025	5:30:00 PM	0
11/14/2025	5:45:00 PM	0
11/14/2025	6:00:00 PM	0
11/14/2025	6:15:00 PM	0
11/14/2025	6:30:00 PM	0
11/14/2025	6:45:00 PM	0
11/14/2025	7:00:00 PM	0
11/14/2025	7:15:00 PM	0
11/14/2025	7:30:00 PM	0
11/14/2025	7:45:00 PM	0
11/14/2025	8:00:00 PM	0
11/14/2025	8:15:00 PM	0
11/14/2025	8:30:00 PM	0
11/14/2025	8:45:00 PM	0
11/14/2025	9:00:00 PM	0
11/14/2025	9:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/14/2025	9:30:00 PM	0
11/14/2025	9:45:00 PM	0
11/14/2025	10:00:00 PM	0
11/14/2025	10:15:00 PM	0
11/14/2025	10:30:00 PM	0
11/14/2025	10:45:00 PM	0
11/14/2025	11:00:00 PM	0
11/14/2025	11:15:00 PM	0
11/14/2025	11:30:00 PM	0
11/14/2025	11:45:00 PM	0
11/15/2025	12:00:00 AM	0
11/15/2025	12:15:00 AM	0
11/15/2025	12:30:00 AM	0
11/15/2025	12:45:00 AM	0
11/15/2025	1:00:00 AM	0
11/15/2025	1:15:00 AM	0
11/15/2025	1:30:00 AM	0
11/15/2025	1:45:00 AM	0
11/15/2025	2:00:00 AM	0
11/15/2025	2:15:00 AM	0
11/15/2025	2:30:00 AM	0
11/15/2025	2:45:00 AM	0
11/15/2025	3:00:00 AM	0
11/15/2025	3:15:00 AM	0
11/15/2025	3:30:00 AM	0
11/15/2025	3:45:00 AM	0
11/15/2025	4:00:00 AM	0
11/15/2025	4:15:00 AM	0
11/15/2025	4:30:00 AM	0
11/15/2025	4:45:00 AM	0
11/15/2025	5:00:00 AM	0
11/15/2025	5:15:00 AM	0
11/15/2025	5:30:00 AM	0
11/15/2025	5:45:00 AM	0
11/15/2025	6:00:00 AM	0
11/15/2025	6:15:00 AM	0
11/15/2025	6:30:00 AM	0
11/15/2025	6:45:00 AM	0
11/15/2025	7:00:00 AM	0
11/15/2025	7:15:00 AM	0
11/15/2025	7:30:00 AM	0
11/15/2025	7:45:00 AM	0
11/15/2025	8:00:00 AM	0
11/15/2025	8:15:00 AM	0
11/15/2025	8:30:00 AM	0
11/15/2025	8:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/15/2025	9:00:00 AM	0
11/15/2025	9:15:00 AM	0
11/15/2025	9:30:00 AM	0
11/15/2025	9:45:00 AM	0
11/15/2025	10:00:00 AM	0
11/15/2025	10:15:00 AM	0
11/15/2025	10:30:00 AM	0
11/15/2025	10:45:00 AM	0
11/15/2025	11:00:00 AM	0
11/15/2025	11:15:00 AM	0
11/15/2025	11:30:00 AM	0
11/15/2025	11:45:00 AM	0
11/15/2025	12:00:00 PM	0
11/15/2025	12:15:00 PM	0
11/15/2025	12:30:00 PM	0
11/15/2025	12:45:00 PM	0
11/15/2025	1:00:00 PM	0
11/15/2025	1:15:00 PM	0
11/15/2025	1:30:00 PM	0
11/15/2025	1:45:00 PM	0
11/15/2025	2:00:00 PM	0
11/15/2025	2:15:00 PM	0
11/15/2025	2:30:00 PM	0
11/15/2025	2:45:00 PM	0
11/15/2025	3:00:00 PM	0
11/15/2025	3:15:00 PM	0
11/15/2025	3:30:00 PM	0
11/15/2025	3:45:00 PM	0
11/15/2025	4:00:00 PM	0
11/15/2025	4:15:00 PM	0
11/15/2025	4:30:00 PM	0
11/15/2025	4:45:00 PM	0
11/15/2025	5:00:00 PM	0
11/15/2025	5:15:00 PM	0
11/15/2025	5:30:00 PM	0
11/15/2025	5:45:00 PM	0
11/15/2025	6:00:00 PM	0
11/15/2025	6:15:00 PM	0
11/15/2025	6:30:00 PM	0
11/15/2025	6:45:00 PM	0
11/15/2025	7:00:00 PM	0
11/15/2025	7:15:00 PM	0
11/15/2025	7:30:00 PM	0
11/15/2025	7:45:00 PM	0
11/15/2025	8:00:00 PM	0
11/15/2025	8:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/15/2025	8:30:00 PM	0
11/15/2025	8:45:00 PM	0
11/15/2025	9:00:00 PM	0
11/15/2025	9:15:00 PM	0
11/15/2025	9:30:00 PM	0
11/15/2025	9:45:00 PM	0
11/15/2025	10:00:00 PM	0
11/15/2025	10:15:00 PM	0
11/15/2025	10:30:00 PM	0
11/15/2025	10:45:00 PM	0
11/15/2025	11:00:00 PM	0
11/15/2025	11:15:00 PM	0
11/15/2025	11:30:00 PM	0
11/15/2025	11:45:00 PM	0
11/16/2025	12:00:00 AM	0
11/16/2025	12:15:00 AM	0
11/16/2025	12:30:00 AM	0
11/16/2025	12:45:00 AM	0
11/16/2025	1:00:00 AM	0
11/16/2025	1:15:00 AM	0
11/16/2025	1:30:00 AM	0
11/16/2025	1:45:00 AM	0
11/16/2025	2:00:00 AM	0
11/16/2025	2:15:00 AM	0
11/16/2025	2:30:00 AM	0
11/16/2025	2:45:00 AM	0
11/16/2025	3:00:00 AM	0
11/16/2025	3:15:00 AM	0
11/16/2025	3:30:00 AM	0
11/16/2025	3:45:00 AM	0
11/16/2025	4:00:00 AM	0
11/16/2025	4:15:00 AM	0
11/16/2025	4:30:00 AM	0
11/16/2025	4:45:00 AM	0
11/16/2025	5:00:00 AM	0
11/16/2025	5:15:00 AM	0
11/16/2025	5:30:00 AM	0
11/16/2025	5:45:00 AM	0
11/16/2025	6:00:00 AM	0
11/16/2025	6:15:00 AM	0
11/16/2025	6:30:00 AM	0
11/16/2025	6:45:00 AM	0
11/16/2025	7:00:00 AM	0
11/16/2025	7:15:00 AM	0
11/16/2025	7:30:00 AM	0
11/16/2025	7:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/16/2025	8:00:00 AM	0
11/16/2025	8:15:00 AM	0
11/16/2025	8:30:00 AM	0
11/16/2025	8:45:00 AM	0
11/16/2025	9:00:00 AM	0
11/16/2025	9:15:00 AM	0
11/16/2025	9:30:00 AM	0
11/16/2025	9:45:00 AM	0
11/16/2025	10:00:00 AM	0
11/16/2025	10:15:00 AM	0
11/16/2025	10:30:00 AM	0
11/16/2025	10:45:00 AM	0
11/16/2025	11:00:00 AM	0
11/16/2025	11:15:00 AM	0
11/16/2025	11:30:00 AM	0
11/16/2025	11:45:00 AM	0
11/16/2025	12:00:00 PM	0
11/16/2025	12:15:00 PM	0
11/16/2025	12:30:00 PM	0
11/16/2025	12:45:00 PM	0
11/16/2025	1:00:00 PM	0
11/16/2025	1:15:00 PM	0
11/16/2025	1:30:00 PM	0
11/16/2025	1:45:00 PM	0
11/16/2025	2:00:00 PM	0
11/16/2025	2:15:00 PM	0
11/16/2025	2:30:00 PM	0
11/16/2025	2:45:00 PM	0
11/16/2025	3:00:00 PM	0
11/16/2025	3:15:00 PM	0
11/16/2025	3:30:00 PM	0
11/16/2025	3:45:00 PM	0
11/16/2025	4:00:00 PM	0
11/16/2025	4:15:00 PM	0
11/16/2025	4:30:00 PM	0
11/16/2025	4:45:00 PM	0
11/16/2025	5:00:00 PM	0
11/16/2025	5:15:00 PM	0
11/16/2025	5:30:00 PM	0
11/16/2025	5:45:00 PM	0
11/16/2025	6:00:00 PM	0
11/16/2025	6:15:00 PM	0
11/16/2025	6:30:00 PM	0
11/16/2025	6:45:00 PM	0
11/16/2025	7:00:00 PM	0
11/16/2025	7:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/16/2025	7:30:00 PM	0
11/16/2025	7:45:00 PM	0
11/16/2025	8:00:00 PM	0
11/16/2025	8:15:00 PM	0
11/16/2025	8:30:00 PM	0
11/16/2025	8:45:00 PM	0
11/16/2025	9:00:00 PM	0
11/16/2025	9:15:00 PM	0
11/16/2025	9:30:00 PM	0
11/16/2025	9:45:00 PM	0
11/16/2025	10:00:00 PM	0
11/16/2025	10:15:00 PM	0
11/16/2025	10:30:00 PM	0
11/16/2025	10:45:00 PM	0
11/16/2025	11:00:00 PM	0
11/16/2025	11:15:00 PM	0
11/16/2025	11:30:00 PM	0
11/16/2025	11:45:00 PM	0
11/17/2025	12:00:00 AM	0
11/17/2025	12:15:00 AM	0
11/17/2025	12:30:00 AM	0
11/17/2025	12:45:00 AM	0
11/17/2025	1:00:00 AM	0
11/17/2025	1:15:00 AM	0
11/17/2025	1:30:00 AM	0
11/17/2025	1:45:00 AM	0
11/17/2025	2:00:00 AM	0
11/17/2025	2:15:00 AM	0
11/17/2025	2:30:00 AM	0
11/17/2025	2:45:00 AM	0
11/17/2025	3:00:00 AM	0
11/17/2025	3:15:00 AM	0
11/17/2025	3:30:00 AM	0
11/17/2025	3:45:00 AM	0
11/17/2025	4:00:00 AM	0
11/17/2025	4:15:00 AM	0
11/17/2025	4:30:00 AM	0
11/17/2025	4:45:00 AM	0
11/17/2025	5:00:00 AM	0
11/17/2025	5:15:00 AM	0
11/17/2025	5:30:00 AM	0
11/17/2025	5:45:00 AM	0
11/17/2025	6:00:00 AM	0
11/17/2025	6:15:00 AM	0
11/17/2025	6:30:00 AM	0
11/17/2025	6:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/17/2025	7:00:00 AM	0
11/17/2025	7:15:00 AM	0
11/17/2025	7:30:00 AM	0
11/17/2025	7:45:00 AM	0
11/17/2025	8:00:00 AM	0
11/17/2025	8:15:00 AM	0
11/17/2025	8:30:00 AM	0
11/17/2025	8:45:00 AM	0
11/17/2025	9:00:00 AM	0
11/17/2025	9:15:00 AM	0
11/17/2025	9:30:00 AM	0
11/17/2025	9:45:00 AM	0
11/17/2025	10:00:00 AM	0
11/17/2025	10:15:00 AM	0
11/17/2025	10:30:00 AM	0
11/17/2025	10:45:00 AM	0
11/17/2025	11:00:00 AM	0
11/17/2025	11:15:00 AM	0
11/17/2025	11:30:00 AM	0
11/17/2025	11:45:00 AM	0
11/17/2025	12:00:00 PM	0
11/17/2025	12:15:00 PM	0
11/17/2025	12:30:00 PM	0
11/17/2025	12:45:00 PM	0
11/17/2025	1:00:00 PM	0
11/17/2025	1:15:00 PM	0
11/17/2025	1:30:00 PM	0
11/17/2025	1:45:00 PM	0
11/17/2025	2:00:00 PM	0
11/17/2025	2:15:00 PM	0
11/17/2025	2:30:00 PM	0
11/17/2025	2:45:00 PM	0
11/17/2025	3:00:00 PM	0
11/17/2025	3:15:00 PM	0
11/17/2025	3:30:00 PM	0
11/17/2025	3:45:00 PM	0
11/17/2025	4:00:00 PM	0
11/17/2025	4:15:00 PM	0
11/17/2025	4:30:00 PM	0
11/17/2025	4:45:00 PM	0
11/17/2025	5:00:00 PM	0
11/17/2025	5:15:00 PM	0
11/17/2025	5:30:00 PM	0
11/17/2025	5:45:00 PM	0
11/17/2025	6:00:00 PM	0
11/17/2025	6:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/17/2025	6:30:00 PM	0
11/17/2025	6:45:00 PM	0
11/17/2025	7:00:00 PM	0
11/17/2025	7:15:00 PM	0
11/17/2025	7:30:00 PM	0
11/17/2025	7:45:00 PM	0
11/17/2025	8:00:00 PM	0
11/17/2025	8:15:00 PM	0
11/17/2025	8:30:00 PM	0
11/17/2025	8:45:00 PM	0
11/17/2025	9:00:00 PM	0
11/17/2025	9:15:00 PM	0
11/17/2025	9:30:00 PM	0
11/17/2025	9:45:00 PM	0
11/17/2025	10:00:00 PM	0
11/17/2025	10:15:00 PM	0
11/17/2025	10:30:00 PM	0
11/17/2025	10:45:00 PM	0
11/17/2025	11:00:00 PM	0
11/17/2025	11:15:00 PM	0
11/17/2025	11:30:00 PM	0
11/17/2025	11:45:00 PM	0
11/18/2025	12:00:00 AM	0
11/18/2025	12:15:00 AM	0
11/18/2025	12:30:00 AM	0
11/18/2025	12:45:00 AM	0
11/18/2025	1:00:00 AM	0
11/18/2025	1:15:00 AM	0
11/18/2025	1:30:00 AM	0
11/18/2025	1:45:00 AM	0
11/18/2025	2:00:00 AM	0
11/18/2025	2:15:00 AM	0
11/18/2025	2:30:00 AM	0
11/18/2025	2:45:00 AM	0
11/18/2025	3:00:00 AM	0
11/18/2025	3:15:00 AM	0
11/18/2025	3:30:00 AM	0
11/18/2025	3:45:00 AM	0
11/18/2025	4:00:00 AM	0
11/18/2025	4:15:00 AM	0
11/18/2025	4:30:00 AM	0
11/18/2025	4:45:00 AM	0
11/18/2025	5:00:00 AM	0
11/18/2025	5:15:00 AM	0
11/18/2025	5:30:00 AM	0
11/18/2025	5:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/18/2025	6:00:00 AM	0
11/18/2025	6:15:00 AM	0
11/18/2025	6:30:00 AM	0
11/18/2025	6:45:00 AM	0
11/18/2025	7:00:00 AM	0
11/18/2025	7:15:00 AM	0
11/18/2025	7:30:00 AM	0
11/18/2025	7:45:00 AM	0
11/18/2025	8:00:00 AM	0
11/18/2025	8:15:00 AM	0
11/18/2025	8:30:00 AM	0
11/18/2025	8:45:00 AM	0
11/18/2025	9:00:00 AM	0
11/18/2025	9:15:00 AM	0
11/18/2025	9:30:00 AM	0
11/18/2025	9:45:00 AM	0
11/18/2025	10:00:00 AM	0
11/18/2025	10:15:00 AM	0
11/18/2025	10:30:00 AM	0
11/18/2025	10:45:00 AM	0
11/18/2025	11:00:00 AM	0
11/18/2025	11:15:00 AM	0
11/18/2025	11:30:00 AM	0
11/18/2025	11:45:00 AM	0
11/18/2025	12:00:00 PM	0
11/18/2025	12:15:00 PM	0
11/18/2025	12:30:00 PM	0
11/18/2025	12:45:00 PM	0
11/18/2025	1:00:00 PM	0
11/18/2025	1:15:00 PM	0
11/18/2025	1:30:00 PM	0
11/18/2025	1:45:00 PM	0
11/18/2025	2:00:00 PM	0
11/18/2025	2:15:00 PM	0
11/18/2025	2:30:00 PM	0
11/18/2025	2:45:00 PM	0
11/18/2025	3:00:00 PM	0
11/18/2025	3:15:00 PM	0
11/18/2025	3:30:00 PM	0
11/18/2025	3:45:00 PM	0
11/18/2025	4:00:00 PM	0
11/18/2025	4:15:00 PM	0
11/18/2025	4:30:00 PM	0
11/18/2025	4:45:00 PM	0
11/18/2025	5:00:00 PM	0
11/18/2025	5:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/18/2025	5:30:00 PM	0
11/18/2025	5:45:00 PM	0
11/18/2025	6:00:00 PM	0
11/18/2025	6:15:00 PM	0
11/18/2025	6:30:00 PM	0
11/18/2025	6:45:00 PM	0
11/18/2025	7:00:00 PM	0
11/18/2025	7:15:00 PM	0
11/18/2025	7:30:00 PM	0
11/18/2025	7:45:00 PM	0
11/18/2025	8:00:00 PM	0
11/18/2025	8:15:00 PM	0
11/18/2025	8:30:00 PM	0
11/18/2025	8:45:00 PM	0
11/18/2025	9:00:00 PM	0
11/18/2025	9:15:00 PM	0
11/18/2025	9:30:00 PM	0
11/18/2025	9:45:00 PM	0
11/18/2025	10:00:00 PM	0
11/18/2025	10:15:00 PM	0
11/18/2025	10:30:00 PM	0
11/18/2025	10:45:00 PM	0
11/18/2025	11:00:00 PM	0
11/18/2025	11:15:00 PM	0
11/18/2025	11:30:00 PM	0
11/18/2025	11:45:00 PM	0
11/19/2025	12:00:00 AM	0
11/19/2025	12:15:00 AM	0
11/19/2025	12:30:00 AM	0
11/19/2025	12:45:00 AM	0
11/19/2025	1:00:00 AM	0
11/19/2025	1:15:00 AM	0
11/19/2025	1:30:00 AM	0
11/19/2025	1:45:00 AM	0
11/19/2025	2:00:00 AM	0
11/19/2025	2:15:00 AM	0
11/19/2025	2:30:00 AM	0
11/19/2025	2:45:00 AM	0
11/19/2025	3:00:00 AM	0
11/19/2025	3:15:00 AM	0
11/19/2025	3:30:00 AM	0
11/19/2025	3:45:00 AM	0
11/19/2025	4:00:00 AM	0
11/19/2025	4:15:00 AM	0
11/19/2025	4:30:00 AM	0
11/19/2025	4:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/19/2025	5:00:00 AM	0
11/19/2025	5:15:00 AM	0
11/19/2025	5:30:00 AM	0
11/19/2025	5:45:00 AM	0
11/19/2025	6:00:00 AM	0
11/19/2025	6:15:00 AM	0
11/19/2025	6:30:00 AM	0
11/19/2025	6:45:00 AM	0
11/19/2025	7:00:00 AM	0
11/19/2025	7:15:00 AM	0
11/19/2025	7:30:00 AM	0
11/19/2025	7:45:00 AM	0
11/19/2025	8:00:00 AM	0
11/19/2025	8:15:00 AM	0
11/19/2025	8:30:00 AM	0
11/19/2025	8:45:00 AM	0
11/19/2025	9:00:00 AM	0
11/19/2025	9:15:00 AM	0
11/19/2025	9:30:00 AM	0
11/19/2025	9:45:00 AM	0
11/19/2025	10:00:00 AM	0
11/19/2025	10:15:00 AM	0
11/19/2025	10:30:00 AM	0
11/19/2025	10:45:00 AM	0
11/19/2025	11:00:00 AM	0
11/19/2025	11:15:00 AM	0
11/19/2025	11:30:00 AM	0
11/19/2025	11:45:00 AM	0
11/19/2025	12:00:00 PM	0
11/19/2025	12:15:00 PM	0
11/19/2025	12:30:00 PM	0
11/19/2025	12:45:00 PM	0
11/19/2025	1:00:00 PM	0
11/19/2025	1:15:00 PM	0
11/19/2025	1:30:00 PM	0
11/19/2025	1:45:00 PM	0
11/19/2025	2:00:00 PM	0
11/19/2025	2:15:00 PM	0
11/19/2025	2:30:00 PM	0
11/19/2025	2:45:00 PM	0
11/19/2025	3:00:00 PM	0
11/19/2025	3:15:00 PM	0
11/19/2025	3:30:00 PM	0
11/19/2025	3:45:00 PM	0
11/19/2025	4:00:00 PM	0
11/19/2025	4:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/19/2025	4:30:00 PM	0
11/19/2025	4:45:00 PM	0
11/19/2025	5:00:00 PM	0
11/19/2025	5:15:00 PM	0
11/19/2025	5:30:00 PM	0
11/19/2025	5:45:00 PM	0
11/19/2025	6:00:00 PM	0
11/19/2025	6:15:00 PM	0
11/19/2025	6:30:00 PM	0
11/19/2025	6:45:00 PM	0
11/19/2025	7:00:00 PM	0
11/19/2025	7:15:00 PM	0
11/19/2025	7:30:00 PM	0
11/19/2025	7:45:00 PM	0
11/19/2025	8:00:00 PM	0
11/19/2025	8:15:00 PM	0
11/19/2025	8:30:00 PM	0
11/19/2025	8:45:00 PM	0
11/19/2025	9:00:00 PM	0
11/19/2025	9:15:00 PM	0
11/19/2025	9:30:00 PM	0
11/19/2025	9:45:00 PM	0
11/19/2025	10:00:00 PM	0
11/19/2025	10:15:00 PM	0
11/19/2025	10:30:00 PM	0
11/19/2025	10:45:00 PM	0
11/19/2025	11:00:00 PM	0
11/19/2025	11:15:00 PM	0
11/19/2025	11:30:00 PM	0
11/19/2025	11:45:00 PM	0
11/20/2025	12:00:00 AM	0
11/20/2025	12:15:00 AM	0
11/20/2025	12:30:00 AM	0
11/20/2025	12:45:00 AM	0
11/20/2025	1:00:00 AM	0
11/20/2025	1:15:00 AM	0
11/20/2025	1:30:00 AM	0
11/20/2025	1:45:00 AM	0
11/20/2025	2:00:00 AM	0
11/20/2025	2:15:00 AM	0
11/20/2025	2:30:00 AM	0
11/20/2025	2:45:00 AM	0
11/20/2025	3:00:00 AM	0
11/20/2025	3:15:00 AM	0
11/20/2025	3:30:00 AM	0
11/20/2025	3:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/20/2025	4:00:00 AM	0
11/20/2025	4:15:00 AM	0
11/20/2025	4:30:00 AM	0
11/20/2025	4:45:00 AM	0
11/20/2025	5:00:00 AM	0
11/20/2025	5:15:00 AM	0
11/20/2025	5:30:00 AM	0
11/20/2025	5:45:00 AM	0
11/20/2025	6:00:00 AM	0
11/20/2025	6:15:00 AM	0
11/20/2025	6:30:00 AM	0
11/20/2025	6:45:00 AM	0
11/20/2025	7:00:00 AM	0
11/20/2025	7:15:00 AM	0
11/20/2025	7:30:00 AM	0
11/20/2025	7:45:00 AM	0
11/20/2025	8:00:00 AM	0
11/20/2025	8:15:00 AM	0
11/20/2025	8:30:00 AM	0
11/20/2025	8:45:00 AM	0
11/20/2025	9:00:00 AM	0
11/20/2025	9:15:00 AM	0
11/20/2025	9:30:00 AM	0
11/20/2025	9:45:00 AM	0
11/20/2025	10:00:00 AM	0
11/20/2025	10:15:00 AM	0
11/20/2025	10:30:00 AM	0
11/20/2025	10:45:00 AM	0
11/20/2025	11:00:00 AM	0
11/20/2025	11:15:00 AM	0
11/20/2025	11:30:00 AM	0
11/20/2025	11:45:00 AM	0
11/20/2025	12:00:00 PM	0
11/20/2025	12:15:00 PM	0
11/20/2025	12:30:00 PM	0
11/20/2025	12:45:00 PM	0
11/20/2025	1:00:00 PM	0
11/20/2025	1:15:00 PM	0
11/20/2025	1:30:00 PM	0
11/20/2025	1:45:00 PM	0
11/20/2025	2:00:00 PM	0
11/20/2025	2:15:00 PM	0
11/20/2025	2:30:00 PM	0
11/20/2025	2:45:00 PM	0
11/20/2025	3:00:00 PM	0
11/20/2025	3:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/20/2025	3:30:00 PM	0
11/20/2025	3:45:00 PM	0
11/20/2025	4:00:00 PM	0
11/20/2025	4:15:00 PM	0
11/20/2025	4:30:00 PM	0
11/20/2025	4:45:00 PM	0
11/20/2025	5:00:00 PM	0
11/20/2025	5:15:00 PM	0
11/20/2025	5:30:00 PM	0
11/20/2025	5:45:00 PM	0
11/20/2025	6:00:00 PM	0
11/20/2025	6:15:00 PM	0
11/20/2025	6:30:00 PM	0
11/20/2025	6:45:00 PM	0
11/20/2025	7:00:00 PM	0
11/20/2025	7:15:00 PM	0
11/20/2025	7:30:00 PM	0
11/20/2025	7:45:00 PM	0
11/20/2025	8:00:00 PM	0
11/20/2025	8:15:00 PM	0
11/20/2025	8:30:00 PM	0
11/20/2025	8:45:00 PM	0
11/20/2025	9:00:00 PM	0
11/20/2025	9:15:00 PM	0
11/20/2025	9:30:00 PM	0
11/20/2025	9:45:00 PM	0
11/20/2025	10:00:00 PM	0
11/20/2025	10:15:00 PM	0
11/20/2025	10:30:00 PM	0
11/20/2025	10:45:00 PM	0
11/20/2025	11:00:00 PM	0
11/20/2025	11:15:00 PM	0
11/20/2025	11:30:00 PM	0
11/20/2025	11:45:00 PM	0
11/21/2025	12:00:00 AM	0
11/21/2025	12:15:00 AM	0
11/21/2025	12:30:00 AM	0
11/21/2025	12:45:00 AM	0
11/21/2025	1:00:00 AM	0
11/21/2025	1:15:00 AM	0
11/21/2025	1:30:00 AM	0
11/21/2025	1:45:00 AM	0
11/21/2025	2:00:00 AM	0
11/21/2025	2:15:00 AM	0
11/21/2025	2:30:00 AM	0
11/21/2025	2:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/21/2025	3:00:00 AM	0
11/21/2025	3:15:00 AM	0
11/21/2025	3:30:00 AM	0
11/21/2025	3:45:00 AM	0
11/21/2025	4:00:00 AM	0
11/21/2025	4:15:00 AM	0
11/21/2025	4:30:00 AM	0
11/21/2025	4:45:00 AM	0
11/21/2025	5:00:00 AM	0
11/21/2025	5:15:00 AM	0
11/21/2025	5:30:00 AM	0
11/21/2025	5:45:00 AM	0
11/21/2025	6:00:00 AM	0
11/21/2025	6:15:00 AM	0
11/21/2025	6:30:00 AM	0
11/21/2025	6:45:00 AM	0
11/21/2025	7:00:00 AM	0
11/21/2025	7:15:00 AM	0
11/21/2025	7:30:00 AM	0
11/21/2025	7:45:00 AM	0
11/21/2025	8:00:00 AM	0
11/21/2025	8:15:00 AM	0
11/21/2025	8:30:00 AM	0
11/21/2025	8:45:00 AM	0
11/21/2025	9:00:00 AM	0
11/21/2025	9:15:00 AM	0
11/21/2025	9:30:00 AM	0
11/21/2025	9:45:00 AM	0
11/21/2025	10:00:00 AM	0
11/21/2025	10:15:00 AM	0
11/21/2025	10:30:00 AM	0
11/21/2025	10:45:00 AM	0
11/21/2025	11:00:00 AM	0
11/21/2025	11:15:00 AM	0
11/21/2025	11:30:00 AM	0
11/21/2025	11:45:00 AM	0
11/21/2025	12:00:00 PM	0
11/21/2025	12:15:00 PM	0
11/21/2025	12:30:00 PM	0
11/21/2025	12:45:00 PM	0
11/21/2025	1:00:00 PM	0
11/21/2025	1:15:00 PM	0
11/21/2025	1:30:00 PM	0
11/21/2025	1:45:00 PM	0
11/21/2025	2:00:00 PM	0
11/21/2025	2:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/21/2025	2:30:00 PM	0
11/21/2025	2:45:00 PM	0
11/21/2025	3:00:00 PM	0
11/21/2025	3:15:00 PM	0
11/21/2025	3:30:00 PM	0
11/21/2025	3:45:00 PM	0
11/21/2025	4:00:00 PM	0
11/21/2025	4:15:00 PM	0
11/21/2025	4:30:00 PM	0
11/21/2025	4:45:00 PM	0
11/21/2025	5:00:00 PM	0
11/21/2025	5:15:00 PM	0
11/21/2025	5:30:00 PM	0
11/21/2025	5:45:00 PM	0
11/21/2025	6:00:00 PM	0
11/21/2025	6:15:00 PM	0
11/21/2025	6:30:00 PM	0
11/21/2025	6:45:00 PM	0
11/21/2025	7:00:00 PM	0
11/21/2025	7:15:00 PM	0
11/21/2025	7:30:00 PM	0
11/21/2025	7:45:00 PM	0
11/21/2025	8:00:00 PM	0
11/21/2025	8:15:00 PM	0
11/21/2025	8:30:00 PM	0
11/21/2025	8:45:00 PM	0
11/21/2025	9:00:00 PM	0
11/21/2025	9:15:00 PM	0
11/21/2025	9:30:00 PM	0
11/21/2025	9:45:00 PM	0
11/21/2025	10:00:00 PM	0
11/21/2025	10:15:00 PM	0
11/21/2025	10:30:00 PM	0
11/21/2025	10:45:00 PM	0
11/21/2025	11:00:00 PM	0
11/21/2025	11:15:00 PM	0
11/21/2025	11:30:00 PM	0
11/21/2025	11:45:00 PM	0
11/22/2025	12:00:00 AM	0
11/22/2025	12:15:00 AM	0
11/22/2025	12:30:00 AM	0
11/22/2025	12:45:00 AM	0
11/22/2025	1:00:00 AM	0
11/22/2025	1:15:00 AM	0
11/22/2025	1:30:00 AM	0
11/22/2025	1:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/22/2025	2:00:00 AM	0
11/22/2025	2:15:00 AM	0
11/22/2025	2:30:00 AM	0
11/22/2025	2:45:00 AM	0
11/22/2025	3:00:00 AM	0
11/22/2025	3:15:00 AM	0
11/22/2025	3:30:00 AM	0
11/22/2025	3:45:00 AM	0
11/22/2025	4:00:00 AM	0
11/22/2025	4:15:00 AM	0
11/22/2025	4:30:00 AM	0
11/22/2025	4:45:00 AM	0
11/22/2025	5:00:00 AM	0
11/22/2025	5:15:00 AM	0
11/22/2025	5:30:00 AM	0
11/22/2025	5:45:00 AM	0
11/22/2025	6:00:00 AM	0
11/22/2025	6:15:00 AM	0
11/22/2025	6:30:00 AM	0
11/22/2025	6:45:00 AM	0
11/22/2025	7:00:00 AM	0
11/22/2025	7:15:00 AM	0
11/22/2025	7:30:00 AM	0
11/22/2025	7:45:00 AM	0
11/22/2025	8:00:00 AM	0
11/22/2025	8:15:00 AM	0
11/22/2025	8:30:00 AM	0
11/22/2025	8:45:00 AM	0
11/22/2025	9:00:00 AM	0
11/22/2025	9:15:00 AM	0
11/22/2025	9:30:00 AM	0
11/22/2025	9:45:00 AM	0
11/22/2025	10:00:00 AM	0
11/22/2025	10:15:00 AM	0
11/22/2025	10:30:00 AM	0
11/22/2025	10:45:00 AM	0
11/22/2025	11:00:00 AM	0
11/22/2025	11:15:00 AM	0
11/22/2025	11:30:00 AM	0
11/22/2025	11:45:00 AM	0
11/22/2025	12:00:00 PM	0
11/22/2025	12:15:00 PM	0
11/22/2025	12:30:00 PM	0
11/22/2025	12:45:00 PM	0
11/22/2025	1:00:00 PM	0
11/22/2025	1:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/22/2025	1:30:00 PM	0
11/22/2025	1:45:00 PM	0
11/22/2025	2:00:00 PM	0
11/22/2025	2:15:00 PM	0
11/22/2025	2:30:00 PM	0
11/22/2025	2:45:00 PM	0
11/22/2025	3:00:00 PM	0
11/22/2025	3:15:00 PM	0
11/22/2025	3:30:00 PM	0
11/22/2025	3:45:00 PM	0
11/22/2025	4:00:00 PM	0
11/22/2025	4:15:00 PM	0
11/22/2025	4:30:00 PM	0
11/22/2025	4:45:00 PM	0
11/22/2025	5:00:00 PM	0
11/22/2025	5:15:00 PM	0
11/22/2025	5:30:00 PM	0
11/22/2025	5:45:00 PM	0
11/22/2025	6:00:00 PM	0
11/22/2025	6:15:00 PM	0
11/22/2025	6:30:00 PM	0
11/22/2025	6:45:00 PM	0
11/22/2025	7:00:00 PM	0
11/22/2025	7:15:00 PM	0
11/22/2025	7:30:00 PM	0
11/22/2025	7:45:00 PM	0
11/22/2025	8:00:00 PM	0
11/22/2025	8:15:00 PM	0
11/22/2025	8:30:00 PM	0
11/22/2025	8:45:00 PM	0
11/22/2025	9:00:00 PM	0
11/22/2025	9:15:00 PM	0
11/22/2025	9:30:00 PM	0
11/22/2025	9:45:00 PM	0
11/22/2025	10:00:00 PM	0
11/22/2025	10:15:00 PM	0
11/22/2025	10:30:00 PM	0
11/22/2025	10:45:00 PM	0
11/22/2025	11:00:00 PM	0
11/22/2025	11:15:00 PM	0
11/22/2025	11:30:00 PM	0
11/22/2025	11:45:00 PM	0
11/23/2025	12:00:00 AM	0
11/23/2025	12:15:00 AM	0
11/23/2025	12:30:00 AM	0
11/23/2025	12:45:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/23/2025	1:00:00 AM	0
11/23/2025	1:15:00 AM	0
11/23/2025	1:30:00 AM	0
11/23/2025	1:45:00 AM	0
11/23/2025	2:00:00 AM	0
11/23/2025	2:15:00 AM	0
11/23/2025	2:30:00 AM	0
11/23/2025	2:45:00 AM	0
11/23/2025	3:00:00 AM	0
11/23/2025	3:15:00 AM	0
11/23/2025	3:30:00 AM	0
11/23/2025	3:45:00 AM	0
11/23/2025	4:00:00 AM	0
11/23/2025	4:15:00 AM	0
11/23/2025	4:30:00 AM	0
11/23/2025	4:45:00 AM	0
11/23/2025	5:00:00 AM	0
11/23/2025	5:15:00 AM	0
11/23/2025	5:30:00 AM	0
11/23/2025	5:45:00 AM	0
11/23/2025	6:00:00 AM	0
11/23/2025	6:15:00 AM	0
11/23/2025	6:30:00 AM	0
11/23/2025	6:45:00 AM	0
11/23/2025	7:00:00 AM	0
11/23/2025	7:15:00 AM	0
11/23/2025	7:30:00 AM	0
11/23/2025	7:45:00 AM	0
11/23/2025	8:00:00 AM	0
11/23/2025	8:15:00 AM	0
11/23/2025	8:30:00 AM	0
11/23/2025	8:45:00 AM	0
11/23/2025	9:00:00 AM	0
11/23/2025	9:15:00 AM	0
11/23/2025	9:30:00 AM	0
11/23/2025	9:45:00 AM	0
11/23/2025	10:00:00 AM	0
11/23/2025	10:15:00 AM	0
11/23/2025	10:30:00 AM	0
11/23/2025	10:45:00 AM	0
11/23/2025	11:00:00 AM	0
11/23/2025	11:15:00 AM	0
11/23/2025	11:30:00 AM	0
11/23/2025	11:45:00 AM	0
11/23/2025	12:00:00 PM	0
11/23/2025	12:15:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/23/2025	12:30:00 PM	0
11/23/2025	12:45:00 PM	0
11/23/2025	1:00:00 PM	0
11/23/2025	1:15:00 PM	0
11/23/2025	1:30:00 PM	0
11/23/2025	1:45:00 PM	0
11/23/2025	2:00:00 PM	0
11/23/2025	2:15:00 PM	0
11/23/2025	2:30:00 PM	0
11/23/2025	2:45:00 PM	0
11/23/2025	3:00:00 PM	0
11/23/2025	3:15:00 PM	0
11/23/2025	3:30:00 PM	0
11/23/2025	3:45:00 PM	0
11/23/2025	4:00:00 PM	0
11/23/2025	4:15:00 PM	0
11/23/2025	4:30:00 PM	0
11/23/2025	4:45:00 PM	0
11/23/2025	5:00:00 PM	0
11/23/2025	5:15:00 PM	0
11/23/2025	5:30:00 PM	0
11/23/2025	5:45:00 PM	0
11/23/2025	6:00:00 PM	0
11/23/2025	6:15:00 PM	0
11/23/2025	6:30:00 PM	0
11/23/2025	6:45:00 PM	0
11/23/2025	7:00:00 PM	0
11/23/2025	7:15:00 PM	0
11/23/2025	7:30:00 PM	0
11/23/2025	7:45:00 PM	0
11/23/2025	8:00:00 PM	0
11/23/2025	8:15:00 PM	0
11/23/2025	8:30:00 PM	0
11/23/2025	8:45:00 PM	0
11/23/2025	9:00:00 PM	0
11/23/2025	9:15:00 PM	0
11/23/2025	9:30:00 PM	0
11/23/2025	9:45:00 PM	0
11/23/2025	10:00:00 PM	0
11/23/2025	10:15:00 PM	0
11/23/2025	10:30:00 PM	0
11/23/2025	10:45:00 PM	0
11/23/2025	11:00:00 PM	0
11/23/2025	11:15:00 PM	0
11/23/2025	11:30:00 PM	0
11/23/2025	11:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/24/2025	12:00:00 AM	0
11/24/2025	12:15:00 AM	0
11/24/2025	12:30:00 AM	0
11/24/2025	12:45:00 AM	0
11/24/2025	1:00:00 AM	0
11/24/2025	1:15:00 AM	0
11/24/2025	1:30:00 AM	0
11/24/2025	1:45:00 AM	0
11/24/2025	2:00:00 AM	0
11/24/2025	2:15:00 AM	0
11/24/2025	2:30:00 AM	0
11/24/2025	2:45:00 AM	0
11/24/2025	3:00:00 AM	0
11/24/2025	3:15:00 AM	0
11/24/2025	3:30:00 AM	0
11/24/2025	3:45:00 AM	0
11/24/2025	4:00:00 AM	0
11/24/2025	4:15:00 AM	0
11/24/2025	4:30:00 AM	0
11/24/2025	4:45:00 AM	0
11/24/2025	5:00:00 AM	0
11/24/2025	5:15:00 AM	0
11/24/2025	5:30:00 AM	0
11/24/2025	5:45:00 AM	0
11/24/2025	6:00:00 AM	0
11/24/2025	6:15:00 AM	0
11/24/2025	6:30:00 AM	0
11/24/2025	6:45:00 AM	0
11/24/2025	7:00:00 AM	0
11/24/2025	7:15:00 AM	0
11/24/2025	7:30:00 AM	0
11/24/2025	7:45:00 AM	0
11/24/2025	8:00:00 AM	0
11/24/2025	8:15:00 AM	0
11/24/2025	8:30:00 AM	0
11/24/2025	8:45:00 AM	0
11/24/2025	9:00:00 AM	0
11/24/2025	9:15:00 AM	0
11/24/2025	9:30:00 AM	0
11/24/2025	9:45:00 AM	0
11/24/2025	10:00:00 AM	0
11/24/2025	10:15:00 AM	0
11/24/2025	10:30:00 AM	0
11/24/2025	10:45:00 AM	0
11/24/2025	11:00:00 AM	0
11/24/2025	11:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/24/2025	11:30:00 AM	0
11/24/2025	11:45:00 AM	0
11/24/2025	12:00:00 PM	0
11/24/2025	12:15:00 PM	0
11/24/2025	12:30:00 PM	0
11/24/2025	12:45:00 PM	0
11/24/2025	1:00:00 PM	0
11/24/2025	1:15:00 PM	0
11/24/2025	1:30:00 PM	0
11/24/2025	1:45:00 PM	0
11/24/2025	2:00:00 PM	0
11/24/2025	2:15:00 PM	0
11/24/2025	2:30:00 PM	0
11/24/2025	2:45:00 PM	0
11/24/2025	3:00:00 PM	0
11/24/2025	3:15:00 PM	0
11/24/2025	3:30:00 PM	0
11/24/2025	3:45:00 PM	0
11/24/2025	4:00:00 PM	0
11/24/2025	4:15:00 PM	0
11/24/2025	4:30:00 PM	0
11/24/2025	4:45:00 PM	0
11/24/2025	5:00:00 PM	0
11/24/2025	5:15:00 PM	0
11/24/2025	5:30:00 PM	0
11/24/2025	5:45:00 PM	0
11/24/2025	6:00:00 PM	0
11/24/2025	6:15:00 PM	0
11/24/2025	6:30:00 PM	0
11/24/2025	6:45:00 PM	0
11/24/2025	7:00:00 PM	0
11/24/2025	7:15:00 PM	0
11/24/2025	7:30:00 PM	0
11/24/2025	7:45:00 PM	0
11/24/2025	8:00:00 PM	0
11/24/2025	8:15:00 PM	0
11/24/2025	8:30:00 PM	0
11/24/2025	8:45:00 PM	0
11/24/2025	9:00:00 PM	0
11/24/2025	9:15:00 PM	0
11/24/2025	9:30:00 PM	0
11/24/2025	9:45:00 PM	0
11/24/2025	10:00:00 PM	0
11/24/2025	10:15:00 PM	0
11/24/2025	10:30:00 PM	0
11/24/2025	10:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/24/2025	11:00:00 PM	0
11/24/2025	11:15:00 PM	0
11/24/2025	11:30:00 PM	0
11/24/2025	11:45:00 PM	0
11/25/2025	12:00:00 AM	0
11/25/2025	12:15:00 AM	0
11/25/2025	12:30:00 AM	0
11/25/2025	12:45:00 AM	0
11/25/2025	1:00:00 AM	0
11/25/2025	1:15:00 AM	0
11/25/2025	1:30:00 AM	0
11/25/2025	1:45:00 AM	0
11/25/2025	2:00:00 AM	0
11/25/2025	2:15:00 AM	0
11/25/2025	2:30:00 AM	0
11/25/2025	2:45:00 AM	0
11/25/2025	3:00:00 AM	0
11/25/2025	3:15:00 AM	0
11/25/2025	3:30:00 AM	0
11/25/2025	3:45:00 AM	0
11/25/2025	4:00:00 AM	0
11/25/2025	4:15:00 AM	0
11/25/2025	4:30:00 AM	0
11/25/2025	4:45:00 AM	0
11/25/2025	5:00:00 AM	0
11/25/2025	5:15:00 AM	0
11/25/2025	5:30:00 AM	0
11/25/2025	5:45:00 AM	0
11/25/2025	6:00:00 AM	0
11/25/2025	6:15:00 AM	0
11/25/2025	6:30:00 AM	0
11/25/2025	6:45:00 AM	0
11/25/2025	7:00:00 AM	0
11/25/2025	7:15:00 AM	0
11/25/2025	7:30:00 AM	0
11/25/2025	7:45:00 AM	0
11/25/2025	8:00:00 AM	0
11/25/2025	8:15:00 AM	0
11/25/2025	8:30:00 AM	0
11/25/2025	8:45:00 AM	0
11/25/2025	9:00:00 AM	0
11/25/2025	9:15:00 AM	0
11/25/2025	9:30:00 AM	0
11/25/2025	9:45:00 AM	0
11/25/2025	10:00:00 AM	0
11/25/2025	10:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/25/2025	10:30:00 AM	0
11/25/2025	10:45:00 AM	0
11/25/2025	11:00:00 AM	0
11/25/2025	11:15:00 AM	0
11/25/2025	11:30:00 AM	0
11/25/2025	11:45:00 AM	0
11/25/2025	12:00:00 PM	0
11/25/2025	12:15:00 PM	0
11/25/2025	12:30:00 PM	0
11/25/2025	12:45:00 PM	0
11/25/2025	1:00:00 PM	0
11/25/2025	1:15:00 PM	0
11/25/2025	1:30:00 PM	0
11/25/2025	1:45:00 PM	0
11/25/2025	2:00:00 PM	0
11/25/2025	2:15:00 PM	0
11/25/2025	2:30:00 PM	0
11/25/2025	2:45:00 PM	0
11/25/2025	3:00:00 PM	0
11/25/2025	3:15:00 PM	0
11/25/2025	3:30:00 PM	0
11/25/2025	3:45:00 PM	0
11/25/2025	4:00:00 PM	0
11/25/2025	4:15:00 PM	0
11/25/2025	4:30:00 PM	0
11/25/2025	4:45:00 PM	0
11/25/2025	5:00:00 PM	0
11/25/2025	5:15:00 PM	0
11/25/2025	5:30:00 PM	0
11/25/2025	5:45:00 PM	0
11/25/2025	6:00:00 PM	0
11/25/2025	6:15:00 PM	0
11/25/2025	6:30:00 PM	0
11/25/2025	6:45:00 PM	0
11/25/2025	7:00:00 PM	0
11/25/2025	7:15:00 PM	0
11/25/2025	7:30:00 PM	0
11/25/2025	7:45:00 PM	0
11/25/2025	8:00:00 PM	0
11/25/2025	8:15:00 PM	0
11/25/2025	8:30:00 PM	0
11/25/2025	8:45:00 PM	0
11/25/2025	9:00:00 PM	0
11/25/2025	9:15:00 PM	0
11/25/2025	9:30:00 PM	0
11/25/2025	9:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/25/2025	10:00:00 PM	0
11/25/2025	10:15:00 PM	0
11/25/2025	10:30:00 PM	0
11/25/2025	10:45:00 PM	0
11/25/2025	11:00:00 PM	0
11/25/2025	11:15:00 PM	0
11/25/2025	11:30:00 PM	0
11/25/2025	11:45:00 PM	0
11/26/2025	12:00:00 AM	0
11/26/2025	12:15:00 AM	0
11/26/2025	12:30:00 AM	0
11/26/2025	12:45:00 AM	0
11/26/2025	1:00:00 AM	0
11/26/2025	1:15:00 AM	0
11/26/2025	1:30:00 AM	0
11/26/2025	1:45:00 AM	0
11/26/2025	2:00:00 AM	0
11/26/2025	2:15:00 AM	0
11/26/2025	2:30:00 AM	0
11/26/2025	2:45:00 AM	0
11/26/2025	3:00:00 AM	0
11/26/2025	3:15:00 AM	0
11/26/2025	3:30:00 AM	0
11/26/2025	3:45:00 AM	0
11/26/2025	4:00:00 AM	0
11/26/2025	4:15:00 AM	0
11/26/2025	4:30:00 AM	0
11/26/2025	4:45:00 AM	0
11/26/2025	5:00:00 AM	0
11/26/2025	5:15:00 AM	0
11/26/2025	5:30:00 AM	0
11/26/2025	5:45:00 AM	0
11/26/2025	6:00:00 AM	0
11/26/2025	6:15:00 AM	0
11/26/2025	6:30:00 AM	0
11/26/2025	6:45:00 AM	0
11/26/2025	7:00:00 AM	0
11/26/2025	7:15:00 AM	0
11/26/2025	7:30:00 AM	0
11/26/2025	7:45:00 AM	0
11/26/2025	8:00:00 AM	0
11/26/2025	8:15:00 AM	0
11/26/2025	8:30:00 AM	0
11/26/2025	8:45:00 AM	0
11/26/2025	9:00:00 AM	0
11/26/2025	9:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/26/2025	9:30:00 AM	0
11/26/2025	9:45:00 AM	0
11/26/2025	10:00:00 AM	0
11/26/2025	10:15:00 AM	0
11/26/2025	10:30:00 AM	0
11/26/2025	10:45:00 AM	0
11/26/2025	11:00:00 AM	0
11/26/2025	11:15:00 AM	0
11/26/2025	11:30:00 AM	0
11/26/2025	11:45:00 AM	0
11/26/2025	12:00:00 PM	0
11/26/2025	12:15:00 PM	0
11/26/2025	12:30:00 PM	0
11/26/2025	12:45:00 PM	0
11/26/2025	1:00:00 PM	0
11/26/2025	1:15:00 PM	0
11/26/2025	1:30:00 PM	0
11/26/2025	1:45:00 PM	0
11/26/2025	2:00:00 PM	0
11/26/2025	2:15:00 PM	0
11/26/2025	2:30:00 PM	0
11/26/2025	2:45:00 PM	0
11/26/2025	3:00:00 PM	0
11/26/2025	3:15:00 PM	0
11/26/2025	3:30:00 PM	0
11/26/2025	3:45:00 PM	0
11/26/2025	4:00:00 PM	0
11/26/2025	4:15:00 PM	0
11/26/2025	4:30:00 PM	0
11/26/2025	4:45:00 PM	0
11/26/2025	5:00:00 PM	0
11/26/2025	5:15:00 PM	0
11/26/2025	5:30:00 PM	0
11/26/2025	5:45:00 PM	0
11/26/2025	6:00:00 PM	0
11/26/2025	6:15:00 PM	0
11/26/2025	6:30:00 PM	0
11/26/2025	6:45:00 PM	0
11/26/2025	7:00:00 PM	0
11/26/2025	7:15:00 PM	0
11/26/2025	7:30:00 PM	0
11/26/2025	7:45:00 PM	0
11/26/2025	8:00:00 PM	0
11/26/2025	8:15:00 PM	0
11/26/2025	8:30:00 PM	0
11/26/2025	8:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/26/2025	9:00:00 PM	0
11/26/2025	9:15:00 PM	0
11/26/2025	9:30:00 PM	0
11/26/2025	9:45:00 PM	0
11/26/2025	10:00:00 PM	0
11/26/2025	10:15:00 PM	0
11/26/2025	10:30:00 PM	0
11/26/2025	10:45:00 PM	0
11/26/2025	11:00:00 PM	0
11/26/2025	11:15:00 PM	0
11/26/2025	11:30:00 PM	0
11/26/2025	11:45:00 PM	0
11/27/2025	12:00:00 AM	0
11/27/2025	12:15:00 AM	0
11/27/2025	12:30:00 AM	0
11/27/2025	12:45:00 AM	0
11/27/2025	1:00:00 AM	0
11/27/2025	1:15:00 AM	0
11/27/2025	1:30:00 AM	0
11/27/2025	1:45:00 AM	0
11/27/2025	2:00:00 AM	0
11/27/2025	2:15:00 AM	0
11/27/2025	2:30:00 AM	0
11/27/2025	2:45:00 AM	0
11/27/2025	3:00:00 AM	0
11/27/2025	3:15:00 AM	0
11/27/2025	3:30:00 AM	0
11/27/2025	3:45:00 AM	0
11/27/2025	4:00:00 AM	0
11/27/2025	4:15:00 AM	0
11/27/2025	4:30:00 AM	0
11/27/2025	4:45:00 AM	0
11/27/2025	5:00:00 AM	0
11/27/2025	5:15:00 AM	0
11/27/2025	5:30:00 AM	0
11/27/2025	5:45:00 AM	0
11/27/2025	6:00:00 AM	0
11/27/2025	6:15:00 AM	0
11/27/2025	6:30:00 AM	0
11/27/2025	6:45:00 AM	0
11/27/2025	7:00:00 AM	0
11/27/2025	7:15:00 AM	0
11/27/2025	7:30:00 AM	0
11/27/2025	7:45:00 AM	0
11/27/2025	8:00:00 AM	0
11/27/2025	8:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/27/2025	8:30:00 AM	0
11/27/2025	8:45:00 AM	0
11/27/2025	9:00:00 AM	0
11/27/2025	9:15:00 AM	0
11/27/2025	9:30:00 AM	0
11/27/2025	9:45:00 AM	0
11/27/2025	10:00:00 AM	0
11/27/2025	10:15:00 AM	0
11/27/2025	10:30:00 AM	0
11/27/2025	10:45:00 AM	0
11/27/2025	11:00:00 AM	0
11/27/2025	11:15:00 AM	0
11/27/2025	11:30:00 AM	0
11/27/2025	11:45:00 AM	0
11/27/2025	12:00:00 PM	0
11/27/2025	12:15:00 PM	0
11/27/2025	12:30:00 PM	0
11/27/2025	12:45:00 PM	0
11/27/2025	1:00:00 PM	0
11/27/2025	1:15:00 PM	0
11/27/2025	1:30:00 PM	0
11/27/2025	1:45:00 PM	0
11/27/2025	2:00:00 PM	0
11/27/2025	2:15:00 PM	0
11/27/2025	2:30:00 PM	0
11/27/2025	2:45:00 PM	0
11/27/2025	3:00:00 PM	0
11/27/2025	3:15:00 PM	0
11/27/2025	3:30:00 PM	0
11/27/2025	3:45:00 PM	0
11/27/2025	4:00:00 PM	0
11/27/2025	4:15:00 PM	0
11/27/2025	4:30:00 PM	0
11/27/2025	4:45:00 PM	0
11/27/2025	5:00:00 PM	0
11/27/2025	5:15:00 PM	0
11/27/2025	5:30:00 PM	0
11/27/2025	5:45:00 PM	0
11/27/2025	6:00:00 PM	0
11/27/2025	6:15:00 PM	0
11/27/2025	6:30:00 PM	0
11/27/2025	6:45:00 PM	0
11/27/2025	7:00:00 PM	0
11/27/2025	7:15:00 PM	0
11/27/2025	7:30:00 PM	0
11/27/2025	7:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/27/2025	8:00:00 PM	0
11/27/2025	8:15:00 PM	0
11/27/2025	8:30:00 PM	0
11/27/2025	8:45:00 PM	0
11/27/2025	9:00:00 PM	0
11/27/2025	9:15:00 PM	0
11/27/2025	9:30:00 PM	0
11/27/2025	9:45:00 PM	0
11/27/2025	10:00:00 PM	0
11/27/2025	10:15:00 PM	0
11/27/2025	10:30:00 PM	0
11/27/2025	10:45:00 PM	0
11/27/2025	11:00:00 PM	0
11/27/2025	11:15:00 PM	0
11/27/2025	11:30:00 PM	0
11/27/2025	11:45:00 PM	0
11/28/2025	12:00:00 AM	0
11/28/2025	12:15:00 AM	0
11/28/2025	12:30:00 AM	0
11/28/2025	12:45:00 AM	0
11/28/2025	1:00:00 AM	0
11/28/2025	1:15:00 AM	0
11/28/2025	1:30:00 AM	0
11/28/2025	1:45:00 AM	0
11/28/2025	2:00:00 AM	0
11/28/2025	2:15:00 AM	0
11/28/2025	2:30:00 AM	0
11/28/2025	2:45:00 AM	0
11/28/2025	3:00:00 AM	0
11/28/2025	3:15:00 AM	0
11/28/2025	3:30:00 AM	0
11/28/2025	3:45:00 AM	0
11/28/2025	4:00:00 AM	0
11/28/2025	4:15:00 AM	0
11/28/2025	4:30:00 AM	0
11/28/2025	4:45:00 AM	0
11/28/2025	5:00:00 AM	0
11/28/2025	5:15:00 AM	0
11/28/2025	5:30:00 AM	0
11/28/2025	5:45:00 AM	0
11/28/2025	6:00:00 AM	0
11/28/2025	6:15:00 AM	0
11/28/2025	6:30:00 AM	0
11/28/2025	6:45:00 AM	0
11/28/2025	7:00:00 AM	0
11/28/2025	7:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/28/2025	7:30:00 AM	0
11/28/2025	7:45:00 AM	0
11/28/2025	8:00:00 AM	0
11/28/2025	8:15:00 AM	0
11/28/2025	8:30:00 AM	0
11/28/2025	8:45:00 AM	0
11/28/2025	9:00:00 AM	0
11/28/2025	9:15:00 AM	0
11/28/2025	9:30:00 AM	0
11/28/2025	9:45:00 AM	0
11/28/2025	10:00:00 AM	0
11/28/2025	10:15:00 AM	0
11/28/2025	10:30:00 AM	0
11/28/2025	10:45:00 AM	0
11/28/2025	11:00:00 AM	0
11/28/2025	11:15:00 AM	0
11/28/2025	11:30:00 AM	0
11/28/2025	11:45:00 AM	0
11/28/2025	12:00:00 PM	0
11/28/2025	12:15:00 PM	0
11/28/2025	12:30:00 PM	0
11/28/2025	12:45:00 PM	0
11/28/2025	1:00:00 PM	0
11/28/2025	1:15:00 PM	0
11/28/2025	1:30:00 PM	0
11/28/2025	1:45:00 PM	0
11/28/2025	2:00:00 PM	0
11/28/2025	2:15:00 PM	0
11/28/2025	2:30:00 PM	0
11/28/2025	2:45:00 PM	0
11/28/2025	3:00:00 PM	0
11/28/2025	3:15:00 PM	0
11/28/2025	3:30:00 PM	0
11/28/2025	3:45:00 PM	0
11/28/2025	4:00:00 PM	0
11/28/2025	4:15:00 PM	0
11/28/2025	4:30:00 PM	0
11/28/2025	4:45:00 PM	0
11/28/2025	5:00:00 PM	0
11/28/2025	5:15:00 PM	0
11/28/2025	5:30:00 PM	0
11/28/2025	5:45:00 PM	0
11/28/2025	6:00:00 PM	0
11/28/2025	6:15:00 PM	0
11/28/2025	6:30:00 PM	0
11/28/2025	6:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/28/2025	7:00:00 PM	0
11/28/2025	7:15:00 PM	0
11/28/2025	7:30:00 PM	0
11/28/2025	7:45:00 PM	0
11/28/2025	8:00:00 PM	0
11/28/2025	8:15:00 PM	0
11/28/2025	8:30:00 PM	0
11/28/2025	8:45:00 PM	0
11/28/2025	9:00:00 PM	0
11/28/2025	9:15:00 PM	0
11/28/2025	9:30:00 PM	0
11/28/2025	9:45:00 PM	0
11/28/2025	10:00:00 PM	0
11/28/2025	10:15:00 PM	0
11/28/2025	10:30:00 PM	0
11/28/2025	10:45:00 PM	0
11/28/2025	11:00:00 PM	0
11/28/2025	11:15:00 PM	0
11/28/2025	11:30:00 PM	0
11/28/2025	11:45:00 PM	0
11/29/2025	12:00:00 AM	0
11/29/2025	12:15:00 AM	0
11/29/2025	12:30:00 AM	0
11/29/2025	12:45:00 AM	0
11/29/2025	1:00:00 AM	0
11/29/2025	1:15:00 AM	0
11/29/2025	1:30:00 AM	0
11/29/2025	1:45:00 AM	0
11/29/2025	2:00:00 AM	0
11/29/2025	2:15:00 AM	0
11/29/2025	2:30:00 AM	0
11/29/2025	2:45:00 AM	0
11/29/2025	3:00:00 AM	0
11/29/2025	3:15:00 AM	0
11/29/2025	3:30:00 AM	0
11/29/2025	3:45:00 AM	0
11/29/2025	4:00:00 AM	0
11/29/2025	4:15:00 AM	0
11/29/2025	4:30:00 AM	0
11/29/2025	4:45:00 AM	0
11/29/2025	5:00:00 AM	0
11/29/2025	5:15:00 AM	0
11/29/2025	5:30:00 AM	0
11/29/2025	5:45:00 AM	0
11/29/2025	6:00:00 AM	0
11/29/2025	6:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/29/2025	6:30:00 AM	0
11/29/2025	6:45:00 AM	0
11/29/2025	7:00:00 AM	0
11/29/2025	7:15:00 AM	0
11/29/2025	7:30:00 AM	0
11/29/2025	7:45:00 AM	0
11/29/2025	8:00:00 AM	0
11/29/2025	8:15:00 AM	0
11/29/2025	8:30:00 AM	0
11/29/2025	8:45:00 AM	0
11/29/2025	9:00:00 AM	0
11/29/2025	9:15:00 AM	0
11/29/2025	9:30:00 AM	0
11/29/2025	9:45:00 AM	0
11/29/2025	10:00:00 AM	0
11/29/2025	10:15:00 AM	0
11/29/2025	10:30:00 AM	0
11/29/2025	10:45:00 AM	0
11/29/2025	11:00:00 AM	0
11/29/2025	11:15:00 AM	0
11/29/2025	11:30:00 AM	0
11/29/2025	11:45:00 AM	0
11/29/2025	12:00:00 PM	0
11/29/2025	12:15:00 PM	0
11/29/2025	12:30:00 PM	0
11/29/2025	12:45:00 PM	0
11/29/2025	1:00:00 PM	0
11/29/2025	1:15:00 PM	0
11/29/2025	1:30:00 PM	0
11/29/2025	1:45:00 PM	0
11/29/2025	2:00:00 PM	0
11/29/2025	2:15:00 PM	0
11/29/2025	2:30:00 PM	0
11/29/2025	2:45:00 PM	0
11/29/2025	3:00:00 PM	0
11/29/2025	3:15:00 PM	0
11/29/2025	3:30:00 PM	0
11/29/2025	3:45:00 PM	0
11/29/2025	4:00:00 PM	0
11/29/2025	4:15:00 PM	0
11/29/2025	4:30:00 PM	0
11/29/2025	4:45:00 PM	0
11/29/2025	5:00:00 PM	0
11/29/2025	5:15:00 PM	0
11/29/2025	5:30:00 PM	0
11/29/2025	5:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/29/2025	6:00:00 PM	0
11/29/2025	6:15:00 PM	0
11/29/2025	6:30:00 PM	0
11/29/2025	6:45:00 PM	0
11/29/2025	7:00:00 PM	0
11/29/2025	7:15:00 PM	0
11/29/2025	7:30:00 PM	0
11/29/2025	7:45:00 PM	0
11/29/2025	8:00:00 PM	0
11/29/2025	8:15:00 PM	0
11/29/2025	8:30:00 PM	0
11/29/2025	8:45:00 PM	0
11/29/2025	9:00:00 PM	0
11/29/2025	9:15:00 PM	0
11/29/2025	9:30:00 PM	0
11/29/2025	9:45:00 PM	0
11/29/2025	10:00:00 PM	0
11/29/2025	10:15:00 PM	0
11/29/2025	10:30:00 PM	0
11/29/2025	10:45:00 PM	0
11/29/2025	11:00:00 PM	0
11/29/2025	11:15:00 PM	0
11/29/2025	11:30:00 PM	0
11/29/2025	11:45:00 PM	0
11/30/2025	12:00:00 AM	0
11/30/2025	12:15:00 AM	0
11/30/2025	12:30:00 AM	0
11/30/2025	12:45:00 AM	0
11/30/2025	1:00:00 AM	0
11/30/2025	1:15:00 AM	0
11/30/2025	1:30:00 AM	0
11/30/2025	1:45:00 AM	0
11/30/2025	2:00:00 AM	0
11/30/2025	2:15:00 AM	0
11/30/2025	2:30:00 AM	0
11/30/2025	2:45:00 AM	0
11/30/2025	3:00:00 AM	0
11/30/2025	3:15:00 AM	0
11/30/2025	3:30:00 AM	0
11/30/2025	3:45:00 AM	0
11/30/2025	4:00:00 AM	0
11/30/2025	4:15:00 AM	0
11/30/2025	4:30:00 AM	0
11/30/2025	4:45:00 AM	0
11/30/2025	5:00:00 AM	0
11/30/2025	5:15:00 AM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/30/2025	5:30:00 AM	0
11/30/2025	5:45:00 AM	0
11/30/2025	6:00:00 AM	0
11/30/2025	6:15:00 AM	0
11/30/2025	6:30:00 AM	0
11/30/2025	6:45:00 AM	0
11/30/2025	7:00:00 AM	0
11/30/2025	7:15:00 AM	0
11/30/2025	7:30:00 AM	0
11/30/2025	7:45:00 AM	0
11/30/2025	8:00:00 AM	0
11/30/2025	8:15:00 AM	0
11/30/2025	8:30:00 AM	0
11/30/2025	8:45:00 AM	0
11/30/2025	9:00:00 AM	0
11/30/2025	9:15:00 AM	0
11/30/2025	9:30:00 AM	0
11/30/2025	9:45:00 AM	0
11/30/2025	10:00:00 AM	0
11/30/2025	10:15:00 AM	0
11/30/2025	10:30:00 AM	0
11/30/2025	10:45:00 AM	0
11/30/2025	11:00:00 AM	0
11/30/2025	11:15:00 AM	0
11/30/2025	11:30:00 AM	0
11/30/2025	11:45:00 AM	0
11/30/2025	12:00:00 PM	0
11/30/2025	12:15:00 PM	0
11/30/2025	12:30:00 PM	0
11/30/2025	12:45:00 PM	0
11/30/2025	1:00:00 PM	0
11/30/2025	1:15:00 PM	0
11/30/2025	1:30:00 PM	0
11/30/2025	1:45:00 PM	0
11/30/2025	2:00:00 PM	0
11/30/2025	2:15:00 PM	0
11/30/2025	2:30:00 PM	0
11/30/2025	2:45:00 PM	0
11/30/2025	3:00:00 PM	0
11/30/2025	3:15:00 PM	0
11/30/2025	3:30:00 PM	0
11/30/2025	3:45:00 PM	0
11/30/2025	4:00:00 PM	0
11/30/2025	4:15:00 PM	0
11/30/2025	4:30:00 PM	0
11/30/2025	4:45:00 PM	0

Locust Ditch Return Gage

DATE	TIME	GAGE
11/30/2025	5:00:00 PM	0
11/30/2025	5:15:00 PM	0
11/30/2025	5:30:00 PM	0
11/30/2025	5:45:00 PM	0
11/30/2025	6:00:00 PM	0
11/30/2025	6:15:00 PM	0
11/30/2025	6:30:00 PM	0
11/30/2025	6:45:00 PM	0
11/30/2025	7:00:00 PM	0
11/30/2025	7:15:00 PM	0
11/30/2025	7:30:00 PM	0
11/30/2025	7:45:00 PM	0
11/30/2025	8:00:00 PM	0
11/30/2025	8:15:00 PM	0
11/30/2025	8:30:00 PM	0
11/30/2025	8:45:00 PM	0
11/30/2025	9:00:00 PM	0
11/30/2025	9:15:00 PM	0
11/30/2025	9:30:00 PM	0
11/30/2025	9:45:00 PM	0
11/30/2025	10:00:00 PM	0
11/30/2025	10:15:00 PM	0
11/30/2025	10:30:00 PM	0
11/30/2025	10:45:00 PM	0
11/30/2025	11:00:00 PM	0
11/30/2025	11:15:00 PM	0
11/30/2025	11:30:00 PM	0
11/30/2025	11:45:00 PM	0

Georges Ditch Return
Station 0217

Date	Flow (cfs)
11/1/2025	0.23
11/2/2025	0.23
11/3/2025	0.25
11/4/2025	0.24
11/5/2025	0.28
11/6/2025	0.24
11/7/2025	0.26
11/8/2025	0.37
11/9/2025	0.35
11/10/2025	0.33
11/11/2025	0.38
11/12/2025	0.38
11/13/2025	0.36
11/14/2025	0.31
11/15/2025	0.51
11/16/2025	0.47
11/17/2025	0.42
11/18/2025	0.36
11/19/2025	0.44
11/20/2025	0.41
11/21/2025	0.38
11/22/2025	0.38
11/23/2025	0.38
11/24/2025	0.34
11/25/2025	0.31
11/26/2025	0.37
11/27/2025	0.38
11/28/2025	0.43
11/29/2025	0.46
11/30/2025	0.42

Georges Ditch Return Gage

DATE	TIME	GAGE
11/1/2025	12:00:00 AM	0.06
11/1/2025	12:15:00 AM	0.06
11/1/2025	12:30:00 AM	0.06
11/1/2025	12:45:00 AM	0.06
11/1/2025	1:00:00 AM	0.06
11/1/2025	1:15:00 AM	0.06
11/1/2025	1:30:00 AM	0.06
11/1/2025	1:45:00 AM	0.06
11/1/2025	2:00:00 AM	0.06
11/1/2025	2:15:00 AM	0.06
11/1/2025	2:30:00 AM	0.06
11/1/2025	2:45:00 AM	0.06
11/1/2025	3:00:00 AM	0.06
11/1/2025	3:15:00 AM	0.06
11/1/2025	3:30:00 AM	0.06
11/1/2025	3:45:00 AM	0.06
11/1/2025	4:00:00 AM	0.06
11/1/2025	4:15:00 AM	0.06
11/1/2025	4:30:00 AM	0.06
11/1/2025	4:45:00 AM	0.06
11/1/2025	5:00:00 AM	0.06
11/1/2025	5:15:00 AM	0.06
11/1/2025	5:30:00 AM	0.06
11/1/2025	5:45:00 AM	0.06
11/1/2025	6:00:00 AM	0.06
11/1/2025	6:15:00 AM	0.06
11/1/2025	6:30:00 AM	0.06
11/1/2025	6:45:00 AM	0.06
11/1/2025	7:00:00 AM	0.06
11/1/2025	7:15:00 AM	0.06
11/1/2025	7:30:00 AM	0.06
11/1/2025	7:45:00 AM	0.06
11/1/2025	8:00:00 AM	0.06
11/1/2025	8:15:00 AM	0.07
11/1/2025	8:30:00 AM	0.06
11/1/2025	8:45:00 AM	0.06
11/1/2025	9:00:00 AM	0.06
11/1/2025	9:15:00 AM	0.06
11/1/2025	9:30:00 AM	0.06
11/1/2025	9:45:00 AM	0.06
11/1/2025	10:00:00 AM	0.06
11/1/2025	10:15:00 AM	0.06
11/1/2025	10:30:00 AM	0.06
11/1/2025	10:45:00 AM	0.06
11/1/2025	11:00:00 AM	0.06
11/1/2025	11:15:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
11/1/2025	11:30:00 AM	0.06
11/1/2025	11:45:00 AM	0.06
11/1/2025	12:00:00 PM	0.06
11/1/2025	12:15:00 PM	0.06
11/1/2025	12:30:00 PM	0.06
11/1/2025	12:45:00 PM	0.06
11/1/2025	1:00:00 PM	0.06
11/1/2025	1:15:00 PM	0.06
11/1/2025	1:30:00 PM	0.06
11/1/2025	1:45:00 PM	0.06
11/1/2025	2:00:00 PM	0.06
11/1/2025	2:15:00 PM	0.06
11/1/2025	2:30:00 PM	0.06
11/1/2025	2:45:00 PM	0.05
11/1/2025	3:00:00 PM	0.05
11/1/2025	3:15:00 PM	0.05
11/1/2025	3:30:00 PM	0.05
11/1/2025	3:45:00 PM	0.05
11/1/2025	4:00:00 PM	0.05
11/1/2025	4:15:00 PM	0.05
11/1/2025	4:30:00 PM	0.05
11/1/2025	4:45:00 PM	0.05
11/1/2025	5:00:00 PM	0.05
11/1/2025	5:15:00 PM	0.05
11/1/2025	5:30:00 PM	0.05
11/1/2025	5:45:00 PM	0.05
11/1/2025	6:00:00 PM	0.05
11/1/2025	6:15:00 PM	0.05
11/1/2025	6:30:00 PM	0.05
11/1/2025	6:45:00 PM	0.05
11/1/2025	7:00:00 PM	0.05
11/1/2025	7:15:00 PM	0.05
11/1/2025	7:30:00 PM	0.05
11/1/2025	7:45:00 PM	0.05
11/1/2025	8:00:00 PM	0.05
11/1/2025	8:15:00 PM	0.05
11/1/2025	8:30:00 PM	0.05
11/1/2025	8:45:00 PM	0.05
11/1/2025	9:00:00 PM	0.05
11/1/2025	9:15:00 PM	0.05
11/1/2025	9:30:00 PM	0.05
11/1/2025	9:45:00 PM	0.05
11/1/2025	10:00:00 PM	0.05
11/1/2025	10:15:00 PM	0.05
11/1/2025	10:30:00 PM	0.05
11/1/2025	10:45:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
11/1/2025	11:00:00 PM	0.05
11/1/2025	11:15:00 PM	0.06
11/1/2025	11:30:00 PM	0.06
11/1/2025	11:45:00 PM	0.06
11/2/2025	12:00:00 AM	0.06
11/2/2025	12:15:00 AM	0.06
11/2/2025	12:30:00 AM	0.06
11/2/2025	12:45:00 AM	0.06
11/2/2025	1:00:00 AM	0.06
11/2/2025	1:15:00 AM	0.06
11/2/2025	1:30:00 AM	0.06
11/2/2025	1:45:00 AM	0.06
11/2/2025	2:00:00 AM	0.06
11/2/2025	2:15:00 AM	0.06
11/2/2025	2:30:00 AM	0.06
11/2/2025	2:45:00 AM	0.06
11/2/2025	3:00:00 AM	0.06
11/2/2025	3:15:00 AM	0.06
11/2/2025	3:30:00 AM	0.06
11/2/2025	3:45:00 AM	0.06
11/2/2025	4:00:00 AM	0.06
11/2/2025	4:15:00 AM	0.06
11/2/2025	4:30:00 AM	0.06
11/2/2025	4:45:00 AM	0.06
11/2/2025	5:00:00 AM	0.06
11/2/2025	5:15:00 AM	0.06
11/2/2025	5:30:00 AM	0.06
11/2/2025	5:45:00 AM	0.06
11/2/2025	6:00:00 AM	0.06
11/2/2025	6:15:00 AM	0.06
11/2/2025	6:30:00 AM	0.06
11/2/2025	6:45:00 AM	0.06
11/2/2025	7:00:00 AM	0.06
11/2/2025	7:15:00 AM	0.06
11/2/2025	7:30:00 AM	0.06
11/2/2025	7:45:00 AM	0.06
11/2/2025	8:00:00 AM	0.06
11/2/2025	8:15:00 AM	0.06
11/2/2025	8:30:00 AM	0.06
11/2/2025	8:45:00 AM	0.06
11/2/2025	9:00:00 AM	0.06
11/2/2025	9:15:00 AM	0.06
11/2/2025	9:30:00 AM	0.06
11/2/2025	9:45:00 AM	0.06
11/2/2025	10:00:00 AM	0.06
11/2/2025	10:15:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
11/2/2025	10:30:00 AM	0.06
11/2/2025	10:45:00 AM	0.06
11/2/2025	11:00:00 AM	0.06
11/2/2025	11:15:00 AM	0.06
11/2/2025	11:30:00 AM	0.06
11/2/2025	11:45:00 AM	0.06
11/2/2025	12:00:00 PM	0.06
11/2/2025	12:15:00 PM	0.06
11/2/2025	12:30:00 PM	0.06
11/2/2025	12:45:00 PM	0.06
11/2/2025	1:00:00 PM	0.06
11/2/2025	1:15:00 PM	0.06
11/2/2025	1:30:00 PM	0.06
11/2/2025	1:45:00 PM	0.06
11/2/2025	2:00:00 PM	0.06
11/2/2025	2:15:00 PM	0.06
11/2/2025	2:30:00 PM	0.06
11/2/2025	2:45:00 PM	0.06
11/2/2025	3:00:00 PM	0.06
11/2/2025	3:15:00 PM	0.06
11/2/2025	3:30:00 PM	0.05
11/2/2025	3:45:00 PM	0.05
11/2/2025	4:00:00 PM	0.05
11/2/2025	4:15:00 PM	0.05
11/2/2025	4:30:00 PM	0.05
11/2/2025	4:45:00 PM	0.05
11/2/2025	5:00:00 PM	0.05
11/2/2025	5:15:00 PM	0.05
11/2/2025	5:30:00 PM	0.05
11/2/2025	5:45:00 PM	0.05
11/2/2025	6:00:00 PM	0.05
11/2/2025	6:15:00 PM	0.05
11/2/2025	6:30:00 PM	0.05
11/2/2025	6:45:00 PM	0.05
11/2/2025	7:00:00 PM	0.05
11/2/2025	7:15:00 PM	0.05
11/2/2025	7:30:00 PM	0.05
11/2/2025	7:45:00 PM	0.05
11/2/2025	8:00:00 PM	0.05
11/2/2025	8:15:00 PM	0.05
11/2/2025	8:30:00 PM	0.05
11/2/2025	8:45:00 PM	0.05
11/2/2025	9:00:00 PM	0.05
11/2/2025	9:15:00 PM	0.05
11/2/2025	9:30:00 PM	0.05
11/2/2025	9:45:00 PM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
11/2/2025	10:00:00 PM	0.05
11/2/2025	10:15:00 PM	0.05
11/2/2025	10:30:00 PM	0.05
11/2/2025	10:45:00 PM	0.05
11/2/2025	11:00:00 PM	0.05
11/2/2025	11:15:00 PM	0.05
11/2/2025	11:30:00 PM	0.05
11/2/2025	11:45:00 PM	0.05
11/3/2025	12:00:00 AM	0.05
11/3/2025	12:15:00 AM	0.05
11/3/2025	12:30:00 AM	0.05
11/3/2025	12:45:00 AM	0.05
11/3/2025	1:00:00 AM	0.06
11/3/2025	1:15:00 AM	0.06
11/3/2025	1:30:00 AM	0.06
11/3/2025	1:45:00 AM	0.06
11/3/2025	2:00:00 AM	0.06
11/3/2025	2:15:00 AM	0.06
11/3/2025	2:30:00 AM	0.06
11/3/2025	2:45:00 AM	0.06
11/3/2025	3:00:00 AM	0.06
11/3/2025	3:15:00 AM	0.06
11/3/2025	3:30:00 AM	0.06
11/3/2025	3:45:00 AM	0.06
11/3/2025	4:00:00 AM	0.06
11/3/2025	4:15:00 AM	0.06
11/3/2025	4:30:00 AM	0.06
11/3/2025	4:45:00 AM	0.06
11/3/2025	5:00:00 AM	0.06
11/3/2025	5:15:00 AM	0.06
11/3/2025	5:30:00 AM	0.06
11/3/2025	5:45:00 AM	0.06
11/3/2025	6:00:00 AM	0.06
11/3/2025	6:15:00 AM	0.06
11/3/2025	6:30:00 AM	0.06
11/3/2025	6:45:00 AM	0.06
11/3/2025	7:00:00 AM	0.06
11/3/2025	7:15:00 AM	0.06
11/3/2025	7:30:00 AM	0.06
11/3/2025	7:45:00 AM	0.06
11/3/2025	8:00:00 AM	0.06
11/3/2025	8:15:00 AM	0.06
11/3/2025	8:30:00 AM	0.06
11/3/2025	8:45:00 AM	0.06
11/3/2025	9:00:00 AM	0.06
11/3/2025	9:15:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
11/3/2025	9:30:00 AM	0.06
11/3/2025	9:45:00 AM	0.06
11/3/2025	10:00:00 AM	0.06
11/3/2025	10:15:00 AM	0.06
11/3/2025	10:30:00 AM	0.06
11/3/2025	10:45:00 AM	0.06
11/3/2025	11:00:00 AM	0.06
11/3/2025	11:15:00 AM	0.06
11/3/2025	11:30:00 AM	0.06
11/3/2025	11:45:00 AM	0.06
11/3/2025	12:00:00 PM	0.06
11/3/2025	12:15:00 PM	0.06
11/3/2025	12:30:00 PM	0.06
11/3/2025	12:45:00 PM	0.06
11/3/2025	1:00:00 PM	0.06
11/3/2025	1:15:00 PM	0.06
11/3/2025	1:30:00 PM	0.06
11/3/2025	1:45:00 PM	0.06
11/3/2025	2:00:00 PM	0.06
11/3/2025	2:15:00 PM	0.06
11/3/2025	2:30:00 PM	0.06
11/3/2025	2:45:00 PM	0.06
11/3/2025	3:00:00 PM	0.06
11/3/2025	3:15:00 PM	0.06
11/3/2025	3:30:00 PM	0.06
11/3/2025	3:45:00 PM	0.06
11/3/2025	4:00:00 PM	0.06
11/3/2025	4:15:00 PM	0.06
11/3/2025	4:30:00 PM	0.06
11/3/2025	4:45:00 PM	0.06
11/3/2025	5:00:00 PM	0.06
11/3/2025	5:15:00 PM	0.06
11/3/2025	5:30:00 PM	0.06
11/3/2025	5:45:00 PM	0.06
11/3/2025	6:00:00 PM	0.06
11/3/2025	6:15:00 PM	0.06
11/3/2025	6:30:00 PM	0.06
11/3/2025	6:45:00 PM	0.06
11/3/2025	7:00:00 PM	0.06
11/3/2025	7:15:00 PM	0.06
11/3/2025	7:30:00 PM	0.06
11/3/2025	7:45:00 PM	0.06
11/3/2025	8:00:00 PM	0.06
11/3/2025	8:15:00 PM	0.06
11/3/2025	8:30:00 PM	0.06
11/3/2025	8:45:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
11/3/2025	9:00:00 PM	0.06
11/3/2025	9:15:00 PM	0.06
11/3/2025	9:30:00 PM	0.06
11/3/2025	9:45:00 PM	0.06
11/3/2025	10:00:00 PM	0.06
11/3/2025	10:15:00 PM	0.06
11/3/2025	10:30:00 PM	0.06
11/3/2025	10:45:00 PM	0.06
11/3/2025	11:00:00 PM	0.06
11/3/2025	11:15:00 PM	0.06
11/3/2025	11:30:00 PM	0.06
11/3/2025	11:45:00 PM	0.06
11/4/2025	12:00:00 AM	0.06
11/4/2025	12:15:00 AM	0.06
11/4/2025	12:30:00 AM	0.06
11/4/2025	12:45:00 AM	0.06
11/4/2025	1:00:00 AM	0.06
11/4/2025	1:15:00 AM	0.06
11/4/2025	1:30:00 AM	0.06
11/4/2025	1:45:00 AM	0.06
11/4/2025	2:00:00 AM	0.06
11/4/2025	2:15:00 AM	0.06
11/4/2025	2:30:00 AM	0.06
11/4/2025	2:45:00 AM	0.06
11/4/2025	3:00:00 AM	0.06
11/4/2025	3:15:00 AM	0.06
11/4/2025	3:30:00 AM	0.06
11/4/2025	3:45:00 AM	0.06
11/4/2025	4:00:00 AM	0.06
11/4/2025	4:15:00 AM	0.06
11/4/2025	4:30:00 AM	0.06
11/4/2025	4:45:00 AM	0.06
11/4/2025	5:00:00 AM	0.06
11/4/2025	5:15:00 AM	0.06
11/4/2025	5:30:00 AM	0.06
11/4/2025	5:45:00 AM	0.06
11/4/2025	6:00:00 AM	0.06
11/4/2025	6:15:00 AM	0.06
11/4/2025	6:30:00 AM	0.06
11/4/2025	6:45:00 AM	0.06
11/4/2025	7:00:00 AM	0.06
11/4/2025	7:15:00 AM	0.06
11/4/2025	7:30:00 AM	0.06
11/4/2025	7:45:00 AM	0.06
11/4/2025	8:00:00 AM	0.06
11/4/2025	8:15:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
11/4/2025	8:30:00 AM	0.06
11/4/2025	8:45:00 AM	0.06
11/4/2025	9:00:00 AM	0.06
11/4/2025	9:15:00 AM	0.06
11/4/2025	9:30:00 AM	0.06
11/4/2025	9:45:00 AM	0.06
11/4/2025	10:00:00 AM	0.06
11/4/2025	10:15:00 AM	0.06
11/4/2025	10:30:00 AM	0.06
11/4/2025	10:45:00 AM	0.06
11/4/2025	11:00:00 AM	0.06
11/4/2025	11:15:00 AM	0.06
11/4/2025	11:30:00 AM	0.06
11/4/2025	11:45:00 AM	0.06
11/4/2025	12:00:00 PM	0.06
11/4/2025	12:15:00 PM	0.06
11/4/2025	12:30:00 PM	0.06
11/4/2025	12:45:00 PM	0.06
11/4/2025	1:00:00 PM	0.06
11/4/2025	1:15:00 PM	0.06
11/4/2025	1:30:00 PM	0.06
11/4/2025	1:45:00 PM	0.06
11/4/2025	2:00:00 PM	0.06
11/4/2025	2:15:00 PM	0.06
11/4/2025	2:30:00 PM	0.06
11/4/2025	2:45:00 PM	0.06
11/4/2025	3:00:00 PM	0.06
11/4/2025	3:15:00 PM	0.06
11/4/2025	3:30:00 PM	0.06
11/4/2025	3:45:00 PM	0.06
11/4/2025	4:00:00 PM	0.06
11/4/2025	4:15:00 PM	0.06
11/4/2025	4:30:00 PM	0.06
11/4/2025	4:45:00 PM	0.06
11/4/2025	5:00:00 PM	0.06
11/4/2025	5:15:00 PM	0.05
11/4/2025	5:30:00 PM	0.05
11/4/2025	5:45:00 PM	0.05
11/4/2025	6:00:00 PM	0.05
11/4/2025	6:15:00 PM	0.05
11/4/2025	6:30:00 PM	0.05
11/4/2025	6:45:00 PM	0.06
11/4/2025	7:00:00 PM	0.06
11/4/2025	7:15:00 PM	0.06
11/4/2025	7:30:00 PM	0.06
11/4/2025	7:45:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
11/4/2025	8:00:00 PM	0.06
11/4/2025	8:15:00 PM	0.06
11/4/2025	8:30:00 PM	0.06
11/4/2025	8:45:00 PM	0.06
11/4/2025	9:00:00 PM	0.06
11/4/2025	9:15:00 PM	0.06
11/4/2025	9:30:00 PM	0.06
11/4/2025	9:45:00 PM	0.06
11/4/2025	10:00:00 PM	0.06
11/4/2025	10:15:00 PM	0.06
11/4/2025	10:30:00 PM	0.06
11/4/2025	10:45:00 PM	0.06
11/4/2025	11:00:00 PM	0.06
11/4/2025	11:15:00 PM	0.06
11/4/2025	11:30:00 PM	0.06
11/4/2025	11:45:00 PM	0.06
11/5/2025	12:00:00 AM	0.06
11/5/2025	12:15:00 AM	0.06
11/5/2025	12:30:00 AM	0.06
11/5/2025	12:45:00 AM	0.07
11/5/2025	1:00:00 AM	0.07
11/5/2025	1:15:00 AM	0.07
11/5/2025	1:30:00 AM	0.07
11/5/2025	1:45:00 AM	0.07
11/5/2025	2:00:00 AM	0.07
11/5/2025	2:15:00 AM	0.07
11/5/2025	2:30:00 AM	0.07
11/5/2025	2:45:00 AM	0.07
11/5/2025	3:00:00 AM	0.07
11/5/2025	3:15:00 AM	0.07
11/5/2025	3:30:00 AM	0.07
11/5/2025	3:45:00 AM	0.07
11/5/2025	4:00:00 AM	0.07
11/5/2025	4:15:00 AM	0.07
11/5/2025	4:30:00 AM	0.07
11/5/2025	4:45:00 AM	0.07
11/5/2025	5:00:00 AM	0.07
11/5/2025	5:15:00 AM	0.07
11/5/2025	5:30:00 AM	0.07
11/5/2025	5:45:00 AM	0.07
11/5/2025	6:00:00 AM	0.07
11/5/2025	6:15:00 AM	0.07
11/5/2025	6:30:00 AM	0.07
11/5/2025	6:45:00 AM	0.07
11/5/2025	7:00:00 AM	0.07
11/5/2025	7:15:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
11/5/2025	7:30:00 AM	0.07
11/5/2025	7:45:00 AM	0.07
11/5/2025	8:00:00 AM	0.07
11/5/2025	8:15:00 AM	0.07
11/5/2025	8:30:00 AM	0.07
11/5/2025	8:45:00 AM	0.07
11/5/2025	9:00:00 AM	0.07
11/5/2025	9:15:00 AM	0.07
11/5/2025	9:30:00 AM	0.07
11/5/2025	9:45:00 AM	0.07
11/5/2025	10:00:00 AM	0.07
11/5/2025	10:15:00 AM	0.07
11/5/2025	10:30:00 AM	0.07
11/5/2025	10:45:00 AM	0.07
11/5/2025	11:00:00 AM	0.07
11/5/2025	11:15:00 AM	0.07
11/5/2025	11:30:00 AM	0.07
11/5/2025	11:45:00 AM	0.07
11/5/2025	12:00:00 PM	0.07
11/5/2025	12:15:00 PM	0.07
11/5/2025	12:30:00 PM	0.07
11/5/2025	12:45:00 PM	0.06
11/5/2025	1:00:00 PM	0.06
11/5/2025	1:15:00 PM	0.06
11/5/2025	1:30:00 PM	0.06
11/5/2025	1:45:00 PM	0.06
11/5/2025	2:00:00 PM	0.06
11/5/2025	2:15:00 PM	0.06
11/5/2025	2:30:00 PM	0.06
11/5/2025	2:45:00 PM	0.06
11/5/2025	3:00:00 PM	0.06
11/5/2025	3:15:00 PM	0.06
11/5/2025	3:30:00 PM	0.06
11/5/2025	3:45:00 PM	0.06
11/5/2025	4:00:00 PM	0.06
11/5/2025	4:15:00 PM	0.06
11/5/2025	4:30:00 PM	0.06
11/5/2025	4:45:00 PM	0.06
11/5/2025	5:00:00 PM	0.06
11/5/2025	5:15:00 PM	0.06
11/5/2025	5:30:00 PM	0.06
11/5/2025	5:45:00 PM	0.06
11/5/2025	6:00:00 PM	0.06
11/5/2025	6:15:00 PM	0.06
11/5/2025	6:30:00 PM	0.06
11/5/2025	6:45:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
11/5/2025	7:00:00 PM	0.06
11/5/2025	7:15:00 PM	0.06
11/5/2025	7:30:00 PM	0.06
11/5/2025	7:45:00 PM	0.06
11/5/2025	8:00:00 PM	0.06
11/5/2025	8:15:00 PM	0.06
11/5/2025	8:30:00 PM	0.06
11/5/2025	8:45:00 PM	0.06
11/5/2025	9:00:00 PM	0.06
11/5/2025	9:15:00 PM	0.06
11/5/2025	9:30:00 PM	0.06
11/5/2025	9:45:00 PM	0.06
11/5/2025	10:00:00 PM	0.06
11/5/2025	10:15:00 PM	0.06
11/5/2025	10:30:00 PM	0.06
11/5/2025	10:45:00 PM	0.06
11/5/2025	11:00:00 PM	0.06
11/5/2025	11:15:00 PM	0.06
11/5/2025	11:30:00 PM	0.06
11/5/2025	11:45:00 PM	0.06
11/6/2025	12:00:00 AM	0.06
11/6/2025	12:15:00 AM	0.06
11/6/2025	12:30:00 AM	0.06
11/6/2025	12:45:00 AM	0.06
11/6/2025	1:00:00 AM	0.06
11/6/2025	1:15:00 AM	0.06
11/6/2025	1:30:00 AM	0.06
11/6/2025	1:45:00 AM	0.06
11/6/2025	2:00:00 AM	0.06
11/6/2025	2:15:00 AM	0.06
11/6/2025	2:30:00 AM	0.06
11/6/2025	2:45:00 AM	0.06
11/6/2025	3:00:00 AM	0.06
11/6/2025	3:15:00 AM	0.06
11/6/2025	3:30:00 AM	0.06
11/6/2025	3:45:00 AM	0.06
11/6/2025	4:00:00 AM	0.06
11/6/2025	4:15:00 AM	0.06
11/6/2025	4:30:00 AM	0.06
11/6/2025	4:45:00 AM	0.06
11/6/2025	5:00:00 AM	0.06
11/6/2025	5:15:00 AM	0.06
11/6/2025	5:30:00 AM	0.06
11/6/2025	5:45:00 AM	0.06
11/6/2025	6:00:00 AM	0.06
11/6/2025	6:15:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
11/6/2025	6:30:00 AM	0.06
11/6/2025	6:45:00 AM	0.06
11/6/2025	7:00:00 AM	0.06
11/6/2025	7:15:00 AM	0.06
11/6/2025	7:30:00 AM	0.06
11/6/2025	7:45:00 AM	0.06
11/6/2025	8:00:00 AM	0.06
11/6/2025	8:15:00 AM	0.06
11/6/2025	8:30:00 AM	0.06
11/6/2025	8:45:00 AM	0.06
11/6/2025	9:00:00 AM	0.06
11/6/2025	9:15:00 AM	0.06
11/6/2025	9:30:00 AM	0.06
11/6/2025	9:45:00 AM	0.06
11/6/2025	10:00:00 AM	0.06
11/6/2025	10:15:00 AM	0.06
11/6/2025	10:30:00 AM	0.06
11/6/2025	10:45:00 AM	0.06
11/6/2025	11:00:00 AM	0.06
11/6/2025	11:15:00 AM	0.06
11/6/2025	11:30:00 AM	0.06
11/6/2025	11:45:00 AM	0.06
11/6/2025	12:00:00 PM	0.06
11/6/2025	12:15:00 PM	0.06
11/6/2025	12:30:00 PM	0.06
11/6/2025	12:45:00 PM	0.06
11/6/2025	1:00:00 PM	0.06
11/6/2025	1:15:00 PM	0.06
11/6/2025	1:30:00 PM	0.06
11/6/2025	1:45:00 PM	0.06
11/6/2025	2:00:00 PM	0.06
11/6/2025	2:15:00 PM	0.06
11/6/2025	2:30:00 PM	0.06
11/6/2025	2:45:00 PM	0.06
11/6/2025	3:00:00 PM	0.06
11/6/2025	3:15:00 PM	0.06
11/6/2025	3:30:00 PM	0.06
11/6/2025	3:45:00 PM	0.06
11/6/2025	4:00:00 PM	0.06
11/6/2025	4:15:00 PM	0.06
11/6/2025	4:30:00 PM	0.06
11/6/2025	4:45:00 PM	0.06
11/6/2025	5:00:00 PM	0.06
11/6/2025	5:15:00 PM	0.06
11/6/2025	5:30:00 PM	0.06
11/6/2025	5:45:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
11/6/2025	6:00:00 PM	0.05
11/6/2025	6:15:00 PM	0.06
11/6/2025	6:30:00 PM	0.05
11/6/2025	6:45:00 PM	0.05
11/6/2025	7:00:00 PM	0.05
11/6/2025	7:15:00 PM	0.05
11/6/2025	7:30:00 PM	0.05
11/6/2025	7:45:00 PM	0.05
11/6/2025	8:00:00 PM	0.05
11/6/2025	8:15:00 PM	0.05
11/6/2025	8:30:00 PM	0.05
11/6/2025	8:45:00 PM	0.05
11/6/2025	9:00:00 PM	0.05
11/6/2025	9:15:00 PM	0.05
11/6/2025	9:30:00 PM	0.05
11/6/2025	9:45:00 PM	0.05
11/6/2025	10:00:00 PM	0.05
11/6/2025	10:15:00 PM	0.05
11/6/2025	10:30:00 PM	0.06
11/6/2025	10:45:00 PM	0.06
11/6/2025	11:00:00 PM	0.06
11/6/2025	11:15:00 PM	0.06
11/6/2025	11:30:00 PM	0.06
11/6/2025	11:45:00 PM	0.06
11/7/2025	12:00:00 AM	0.06
11/7/2025	12:15:00 AM	0.06
11/7/2025	12:30:00 AM	0.06
11/7/2025	12:45:00 AM	0.06
11/7/2025	1:00:00 AM	0.06
11/7/2025	1:15:00 AM	0.06
11/7/2025	1:30:00 AM	0.06
11/7/2025	1:45:00 AM	0.06
11/7/2025	2:00:00 AM	0.06
11/7/2025	2:15:00 AM	0.06
11/7/2025	2:30:00 AM	0.06
11/7/2025	2:45:00 AM	0.06
11/7/2025	3:00:00 AM	0.06
11/7/2025	3:15:00 AM	0.06
11/7/2025	3:30:00 AM	0.06
11/7/2025	3:45:00 AM	0.06
11/7/2025	4:00:00 AM	0.06
11/7/2025	4:15:00 AM	0.06
11/7/2025	4:30:00 AM	0.06
11/7/2025	4:45:00 AM	0.06
11/7/2025	5:00:00 AM	0.06
11/7/2025	5:15:00 AM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
11/7/2025	5:30:00 AM	0.06
11/7/2025	5:45:00 AM	0.06
11/7/2025	6:00:00 AM	0.06
11/7/2025	6:15:00 AM	0.06
11/7/2025	6:30:00 AM	0.06
11/7/2025	6:45:00 AM	0.06
11/7/2025	7:00:00 AM	0.06
11/7/2025	7:15:00 AM	0.06
11/7/2025	7:30:00 AM	0.06
11/7/2025	7:45:00 AM	0.06
11/7/2025	8:00:00 AM	0.06
11/7/2025	8:15:00 AM	0.06
11/7/2025	8:30:00 AM	0.06
11/7/2025	8:45:00 AM	0.07
11/7/2025	9:00:00 AM	0.06
11/7/2025	9:15:00 AM	0.06
11/7/2025	9:30:00 AM	0.07
11/7/2025	9:45:00 AM	0.07
11/7/2025	10:00:00 AM	0.07
11/7/2025	10:15:00 AM	0.07
11/7/2025	10:30:00 AM	0.07
11/7/2025	10:45:00 AM	0.07
11/7/2025	11:00:00 AM	0.07
11/7/2025	11:15:00 AM	0.07
11/7/2025	11:30:00 AM	0.07
11/7/2025	11:45:00 AM	0.07
11/7/2025	12:00:00 PM	0.07
11/7/2025	12:15:00 PM	0.07
11/7/2025	12:30:00 PM	0.07
11/7/2025	12:45:00 PM	0.07
11/7/2025	1:00:00 PM	0.07
11/7/2025	1:15:00 PM	0.07
11/7/2025	1:30:00 PM	0.07
11/7/2025	1:45:00 PM	0.07
11/7/2025	2:00:00 PM	0.06
11/7/2025	2:15:00 PM	0.06
11/7/2025	2:30:00 PM	0.06
11/7/2025	2:45:00 PM	0.06
11/7/2025	3:00:00 PM	0.06
11/7/2025	3:15:00 PM	0.06
11/7/2025	3:30:00 PM	0.06
11/7/2025	3:45:00 PM	0.06
11/7/2025	4:00:00 PM	0.06
11/7/2025	4:15:00 PM	0.06
11/7/2025	4:30:00 PM	0.06
11/7/2025	4:45:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
11/7/2025	5:00:00 PM	0.06
11/7/2025	5:15:00 PM	0.06
11/7/2025	5:30:00 PM	0.06
11/7/2025	5:45:00 PM	0.06
11/7/2025	6:00:00 PM	0.06
11/7/2025	6:15:00 PM	0.06
11/7/2025	6:30:00 PM	0.06
11/7/2025	6:45:00 PM	0.06
11/7/2025	7:00:00 PM	0.06
11/7/2025	7:15:00 PM	0.06
11/7/2025	7:30:00 PM	0.06
11/7/2025	7:45:00 PM	0.06
11/7/2025	8:00:00 PM	0.06
11/7/2025	8:15:00 PM	0.06
11/7/2025	8:30:00 PM	0.06
11/7/2025	8:45:00 PM	0.06
11/7/2025	9:00:00 PM	0.06
11/7/2025	9:15:00 PM	0.06
11/7/2025	9:30:00 PM	0.06
11/7/2025	9:45:00 PM	0.06
11/7/2025	10:00:00 PM	0.06
11/7/2025	10:15:00 PM	0.06
11/7/2025	10:30:00 PM	0.06
11/7/2025	10:45:00 PM	0.06
11/7/2025	11:00:00 PM	0.06
11/7/2025	11:15:00 PM	0.06
11/7/2025	11:30:00 PM	0.06
11/7/2025	11:45:00 PM	0.06
11/8/2025	12:00:00 AM	0.06
11/8/2025	12:15:00 AM	0.07
11/8/2025	12:30:00 AM	0.07
11/8/2025	12:45:00 AM	0.07
11/8/2025	1:00:00 AM	0.07
11/8/2025	1:15:00 AM	0.07
11/8/2025	1:30:00 AM	0.07
11/8/2025	1:45:00 AM	0.07
11/8/2025	2:00:00 AM	0.07
11/8/2025	2:15:00 AM	0.07
11/8/2025	2:30:00 AM	0.07
11/8/2025	2:45:00 AM	0.07
11/8/2025	3:00:00 AM	0.07
11/8/2025	3:15:00 AM	0.07
11/8/2025	3:30:00 AM	0.07
11/8/2025	3:45:00 AM	0.08
11/8/2025	4:00:00 AM	0.08
11/8/2025	4:15:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/8/2025	4:30:00 AM	0.08
11/8/2025	4:45:00 AM	0.08
11/8/2025	5:00:00 AM	0.08
11/8/2025	5:15:00 AM	0.08
11/8/2025	5:30:00 AM	0.08
11/8/2025	5:45:00 AM	0.08
11/8/2025	6:00:00 AM	0.08
11/8/2025	6:15:00 AM	0.08
11/8/2025	6:30:00 AM	0.08
11/8/2025	6:45:00 AM	0.08
11/8/2025	7:00:00 AM	0.08
11/8/2025	7:15:00 AM	0.08
11/8/2025	7:30:00 AM	0.08
11/8/2025	7:45:00 AM	0.08
11/8/2025	8:00:00 AM	0.08
11/8/2025	8:15:00 AM	0.08
11/8/2025	8:30:00 AM	0.08
11/8/2025	8:45:00 AM	0.08
11/8/2025	9:00:00 AM	0.08
11/8/2025	9:15:00 AM	0.08
11/8/2025	9:30:00 AM	0.08
11/8/2025	9:45:00 AM	0.08
11/8/2025	10:00:00 AM	0.08
11/8/2025	10:15:00 AM	0.08
11/8/2025	10:30:00 AM	0.08
11/8/2025	10:45:00 AM	0.08
11/8/2025	11:00:00 AM	0.08
11/8/2025	11:15:00 AM	0.08
11/8/2025	11:30:00 AM	0.08
11/8/2025	11:45:00 AM	0.08
11/8/2025	12:00:00 PM	0.08
11/8/2025	12:15:00 PM	0.08
11/8/2025	12:30:00 PM	0.08
11/8/2025	12:45:00 PM	0.08
11/8/2025	1:00:00 PM	0.08
11/8/2025	1:15:00 PM	0.08
11/8/2025	1:30:00 PM	0.08
11/8/2025	1:45:00 PM	0.08
11/8/2025	2:00:00 PM	0.08
11/8/2025	2:15:00 PM	0.08
11/8/2025	2:30:00 PM	0.08
11/8/2025	2:45:00 PM	0.08
11/8/2025	3:00:00 PM	0.08
11/8/2025	3:15:00 PM	0.08
11/8/2025	3:30:00 PM	0.08
11/8/2025	3:45:00 PM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/8/2025	4:00:00 PM	0.08
11/8/2025	4:15:00 PM	0.08
11/8/2025	4:30:00 PM	0.08
11/8/2025	4:45:00 PM	0.08
11/8/2025	5:00:00 PM	0.08
11/8/2025	5:15:00 PM	0.08
11/8/2025	5:30:00 PM	0.08
11/8/2025	5:45:00 PM	0.08
11/8/2025	6:00:00 PM	0.08
11/8/2025	6:15:00 PM	0.08
11/8/2025	6:30:00 PM	0.08
11/8/2025	6:45:00 PM	0.08
11/8/2025	7:00:00 PM	0.08
11/8/2025	7:15:00 PM	0.08
11/8/2025	7:30:00 PM	0.08
11/8/2025	7:45:00 PM	0.08
11/8/2025	8:00:00 PM	0.08
11/8/2025	8:15:00 PM	0.08
11/8/2025	8:30:00 PM	0.08
11/8/2025	8:45:00 PM	0.08
11/8/2025	9:00:00 PM	0.08
11/8/2025	9:15:00 PM	0.08
11/8/2025	9:30:00 PM	0.08
11/8/2025	9:45:00 PM	0.08
11/8/2025	10:00:00 PM	0.08
11/8/2025	10:15:00 PM	0.08
11/8/2025	10:30:00 PM	0.08
11/8/2025	10:45:00 PM	0.08
11/8/2025	11:00:00 PM	0.08
11/8/2025	11:15:00 PM	0.08
11/8/2025	11:30:00 PM	0.08
11/8/2025	11:45:00 PM	0.08
11/9/2025	12:00:00 AM	0.08
11/9/2025	12:15:00 AM	0.08
11/9/2025	12:30:00 AM	0.08
11/9/2025	12:45:00 AM	0.08
11/9/2025	1:00:00 AM	0.08
11/9/2025	1:15:00 AM	0.08
11/9/2025	1:30:00 AM	0.08
11/9/2025	1:45:00 AM	0.08
11/9/2025	2:00:00 AM	0.08
11/9/2025	2:15:00 AM	0.08
11/9/2025	2:30:00 AM	0.08
11/9/2025	2:45:00 AM	0.08
11/9/2025	3:00:00 AM	0.08
11/9/2025	3:15:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/9/2025	3:30:00 AM	0.08
11/9/2025	3:45:00 AM	0.08
11/9/2025	4:00:00 AM	0.08
11/9/2025	4:15:00 AM	0.08
11/9/2025	4:30:00 AM	0.08
11/9/2025	4:45:00 AM	0.08
11/9/2025	5:00:00 AM	0.08
11/9/2025	5:15:00 AM	0.08
11/9/2025	5:30:00 AM	0.08
11/9/2025	5:45:00 AM	0.08
11/9/2025	6:00:00 AM	0.08
11/9/2025	6:15:00 AM	0.08
11/9/2025	6:30:00 AM	0.08
11/9/2025	6:45:00 AM	0.08
11/9/2025	7:00:00 AM	0.08
11/9/2025	7:15:00 AM	0.08
11/9/2025	7:30:00 AM	0.08
11/9/2025	7:45:00 AM	0.08
11/9/2025	8:00:00 AM	0.08
11/9/2025	8:15:00 AM	0.08
11/9/2025	8:30:00 AM	0.08
11/9/2025	8:45:00 AM	0.08
11/9/2025	9:00:00 AM	0.08
11/9/2025	9:15:00 AM	0.08
11/9/2025	9:30:00 AM	0.08
11/9/2025	9:45:00 AM	0.08
11/9/2025	10:00:00 AM	0.08
11/9/2025	10:15:00 AM	0.08
11/9/2025	10:30:00 AM	0.08
11/9/2025	10:45:00 AM	0.08
11/9/2025	11:00:00 AM	0.08
11/9/2025	11:15:00 AM	0.08
11/9/2025	11:30:00 AM	0.08
11/9/2025	11:45:00 AM	0.07
11/9/2025	12:00:00 PM	0.07
11/9/2025	12:15:00 PM	0.07
11/9/2025	12:30:00 PM	0.07
11/9/2025	12:45:00 PM	0.07
11/9/2025	1:00:00 PM	0.07
11/9/2025	1:15:00 PM	0.07
11/9/2025	1:30:00 PM	0.07
11/9/2025	1:45:00 PM	0.07
11/9/2025	2:00:00 PM	0.07
11/9/2025	2:15:00 PM	0.07
11/9/2025	2:30:00 PM	0.07
11/9/2025	2:45:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
11/9/2025	3:00:00 PM	0.07
11/9/2025	3:15:00 PM	0.07
11/9/2025	3:30:00 PM	0.07
11/9/2025	3:45:00 PM	0.07
11/9/2025	4:00:00 PM	0.07
11/9/2025	4:15:00 PM	0.07
11/9/2025	4:30:00 PM	0.07
11/9/2025	4:45:00 PM	0.07
11/9/2025	5:00:00 PM	0.07
11/9/2025	5:15:00 PM	0.07
11/9/2025	5:30:00 PM	0.07
11/9/2025	5:45:00 PM	0.07
11/9/2025	6:00:00 PM	0.07
11/9/2025	6:15:00 PM	0.07
11/9/2025	6:30:00 PM	0.07
11/9/2025	6:45:00 PM	0.07
11/9/2025	7:00:00 PM	0.07
11/9/2025	7:15:00 PM	0.07
11/9/2025	7:30:00 PM	0.07
11/9/2025	7:45:00 PM	0.07
11/9/2025	8:00:00 PM	0.07
11/9/2025	8:15:00 PM	0.07
11/9/2025	8:30:00 PM	0.07
11/9/2025	8:45:00 PM	0.07
11/9/2025	9:00:00 PM	0.07
11/9/2025	9:15:00 PM	0.07
11/9/2025	9:30:00 PM	0.07
11/9/2025	9:45:00 PM	0.07
11/9/2025	10:00:00 PM	0.07
11/9/2025	10:15:00 PM	0.07
11/9/2025	10:30:00 PM	0.07
11/9/2025	10:45:00 PM	0.07
11/9/2025	11:00:00 PM	0.07
11/9/2025	11:15:00 PM	0.07
11/9/2025	11:30:00 PM	0.07
11/9/2025	11:45:00 PM	0.07
11/10/2025	12:00:00 AM	0.07
11/10/2025	12:15:00 AM	0.07
11/10/2025	12:30:00 AM	0.07
11/10/2025	12:45:00 AM	0.07
11/10/2025	1:00:00 AM	0.07
11/10/2025	1:15:00 AM	0.07
11/10/2025	1:30:00 AM	0.07
11/10/2025	1:45:00 AM	0.07
11/10/2025	2:00:00 AM	0.07
11/10/2025	2:15:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
11/10/2025	2:30:00 AM	0.07
11/10/2025	2:45:00 AM	0.07
11/10/2025	3:00:00 AM	0.07
11/10/2025	3:15:00 AM	0.07
11/10/2025	3:30:00 AM	0.07
11/10/2025	3:45:00 AM	0.07
11/10/2025	4:00:00 AM	0.07
11/10/2025	4:15:00 AM	0.07
11/10/2025	4:30:00 AM	0.07
11/10/2025	4:45:00 AM	0.07
11/10/2025	5:00:00 AM	0.07
11/10/2025	5:15:00 AM	0.07
11/10/2025	5:30:00 AM	0.07
11/10/2025	5:45:00 AM	0.07
11/10/2025	6:00:00 AM	0.07
11/10/2025	6:15:00 AM	0.07
11/10/2025	6:30:00 AM	0.07
11/10/2025	6:45:00 AM	0.07
11/10/2025	7:00:00 AM	0.07
11/10/2025	7:15:00 AM	0.07
11/10/2025	7:30:00 AM	0.07
11/10/2025	7:45:00 AM	0.07
11/10/2025	8:00:00 AM	0.07
11/10/2025	8:15:00 AM	0.07
11/10/2025	8:30:00 AM	0.07
11/10/2025	8:45:00 AM	0.07
11/10/2025	9:00:00 AM	0.07
11/10/2025	9:15:00 AM	0.07
11/10/2025	9:30:00 AM	0.07
11/10/2025	9:45:00 AM	0.07
11/10/2025	10:00:00 AM	0.07
11/10/2025	10:15:00 AM	0.07
11/10/2025	10:30:00 AM	0.07
11/10/2025	10:45:00 AM	0.07
11/10/2025	11:00:00 AM	0.07
11/10/2025	11:15:00 AM	0.07
11/10/2025	11:30:00 AM	0.07
11/10/2025	11:45:00 AM	0.07
11/10/2025	12:00:00 PM	0.07
11/10/2025	12:15:00 PM	0.07
11/10/2025	12:30:00 PM	0.07
11/10/2025	12:45:00 PM	0.07
11/10/2025	1:00:00 PM	0.07
11/10/2025	1:15:00 PM	0.07
11/10/2025	1:30:00 PM	0.07
11/10/2025	1:45:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
11/10/2025	2:00:00 PM	0.07
11/10/2025	2:15:00 PM	0.07
11/10/2025	2:30:00 PM	0.07
11/10/2025	2:45:00 PM	0.07
11/10/2025	3:00:00 PM	0.07
11/10/2025	3:15:00 PM	0.07
11/10/2025	3:30:00 PM	0.07
11/10/2025	3:45:00 PM	0.07
11/10/2025	4:00:00 PM	0.07
11/10/2025	4:15:00 PM	0.07
11/10/2025	4:30:00 PM	0.07
11/10/2025	4:45:00 PM	0.07
11/10/2025	5:00:00 PM	0.07
11/10/2025	5:15:00 PM	0.07
11/10/2025	5:30:00 PM	0.07
11/10/2025	5:45:00 PM	0.07
11/10/2025	6:00:00 PM	0.07
11/10/2025	6:15:00 PM	0.07
11/10/2025	6:30:00 PM	0.07
11/10/2025	6:45:00 PM	0.08
11/10/2025	7:00:00 PM	0.08
11/10/2025	7:15:00 PM	0.08
11/10/2025	7:30:00 PM	0.08
11/10/2025	7:45:00 PM	0.08
11/10/2025	8:00:00 PM	0.08
11/10/2025	8:15:00 PM	0.08
11/10/2025	8:30:00 PM	0.08
11/10/2025	8:45:00 PM	0.08
11/10/2025	9:00:00 PM	0.08
11/10/2025	9:15:00 PM	0.08
11/10/2025	9:30:00 PM	0.08
11/10/2025	9:45:00 PM	0.08
11/10/2025	10:00:00 PM	0.08
11/10/2025	10:15:00 PM	0.08
11/10/2025	10:30:00 PM	0.08
11/10/2025	10:45:00 PM	0.08
11/10/2025	11:00:00 PM	0.08
11/10/2025	11:15:00 PM	0.08
11/10/2025	11:30:00 PM	0.08
11/10/2025	11:45:00 PM	0.08
11/11/2025	12:00:00 AM	0.08
11/11/2025	12:15:00 AM	0.08
11/11/2025	12:30:00 AM	0.08
11/11/2025	12:45:00 AM	0.08
11/11/2025	1:00:00 AM	0.08
11/11/2025	1:15:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/11/2025	1:30:00 AM	0.08
11/11/2025	1:45:00 AM	0.08
11/11/2025	2:00:00 AM	0.08
11/11/2025	2:15:00 AM	0.08
11/11/2025	2:30:00 AM	0.08
11/11/2025	2:45:00 AM	0.08
11/11/2025	3:00:00 AM	0.08
11/11/2025	3:15:00 AM	0.08
11/11/2025	3:30:00 AM	0.08
11/11/2025	3:45:00 AM	0.08
11/11/2025	4:00:00 AM	0.08
11/11/2025	4:15:00 AM	0.08
11/11/2025	4:30:00 AM	0.08
11/11/2025	4:45:00 AM	0.08
11/11/2025	5:00:00 AM	0.08
11/11/2025	5:15:00 AM	0.08
11/11/2025	5:30:00 AM	0.08
11/11/2025	5:45:00 AM	0.08
11/11/2025	6:00:00 AM	0.08
11/11/2025	6:15:00 AM	0.08
11/11/2025	6:30:00 AM	0.08
11/11/2025	6:45:00 AM	0.08
11/11/2025	7:00:00 AM	0.08
11/11/2025	7:15:00 AM	0.08
11/11/2025	7:30:00 AM	0.08
11/11/2025	7:45:00 AM	0.08
11/11/2025	8:00:00 AM	0.08
11/11/2025	8:15:00 AM	0.08
11/11/2025	8:30:00 AM	0.08
11/11/2025	8:45:00 AM	0.08
11/11/2025	9:00:00 AM	0.08
11/11/2025	9:15:00 AM	0.08
11/11/2025	9:30:00 AM	0.08
11/11/2025	9:45:00 AM	0.08
11/11/2025	10:00:00 AM	0.08
11/11/2025	10:15:00 AM	0.08
11/11/2025	10:30:00 AM	0.08
11/11/2025	10:45:00 AM	0.08
11/11/2025	11:00:00 AM	0.08
11/11/2025	11:15:00 AM	0.08
11/11/2025	11:30:00 AM	0.08
11/11/2025	11:45:00 AM	0.08
11/11/2025	12:00:00 PM	0.08
11/11/2025	12:15:00 PM	0.08
11/11/2025	12:30:00 PM	0.08
11/11/2025	12:45:00 PM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/11/2025	1:00:00 PM	0.08
11/11/2025	1:15:00 PM	0.08
11/11/2025	1:30:00 PM	0.08
11/11/2025	1:45:00 PM	0.08
11/11/2025	2:00:00 PM	0.08
11/11/2025	2:15:00 PM	0.08
11/11/2025	2:30:00 PM	0.08
11/11/2025	2:45:00 PM	0.08
11/11/2025	3:00:00 PM	0.08
11/11/2025	3:15:00 PM	0.08
11/11/2025	3:30:00 PM	0.08
11/11/2025	3:45:00 PM	0.08
11/11/2025	4:00:00 PM	0.08
11/11/2025	4:15:00 PM	0.08
11/11/2025	4:30:00 PM	0.08
11/11/2025	4:45:00 PM	0.08
11/11/2025	5:00:00 PM	0.08
11/11/2025	5:15:00 PM	0.08
11/11/2025	5:30:00 PM	0.08
11/11/2025	5:45:00 PM	0.08
11/11/2025	6:00:00 PM	0.08
11/11/2025	6:15:00 PM	0.08
11/11/2025	6:30:00 PM	0.08
11/11/2025	6:45:00 PM	0.08
11/11/2025	7:00:00 PM	0.08
11/11/2025	7:15:00 PM	0.08
11/11/2025	7:30:00 PM	0.08
11/11/2025	7:45:00 PM	0.08
11/11/2025	8:00:00 PM	0.08
11/11/2025	8:15:00 PM	0.08
11/11/2025	8:30:00 PM	0.08
11/11/2025	8:45:00 PM	0.08
11/11/2025	9:00:00 PM	0.08
11/11/2025	9:15:00 PM	0.08
11/11/2025	9:30:00 PM	0.08
11/11/2025	9:45:00 PM	0.08
11/11/2025	10:00:00 PM	0.08
11/11/2025	10:15:00 PM	0.08
11/11/2025	10:30:00 PM	0.08
11/11/2025	10:45:00 PM	0.08
11/11/2025	11:00:00 PM	0.08
11/11/2025	11:15:00 PM	0.08
11/11/2025	11:30:00 PM	0.08
11/11/2025	11:45:00 PM	0.08
11/12/2025	12:00:00 AM	0.08
11/12/2025	12:15:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/12/2025	12:30:00 AM	0.08
11/12/2025	12:45:00 AM	0.08
11/12/2025	1:00:00 AM	0.08
11/12/2025	1:15:00 AM	0.08
11/12/2025	1:30:00 AM	0.08
11/12/2025	1:45:00 AM	0.08
11/12/2025	2:00:00 AM	0.08
11/12/2025	2:15:00 AM	0.08
11/12/2025	2:30:00 AM	0.08
11/12/2025	2:45:00 AM	0.08
11/12/2025	3:00:00 AM	0.08
11/12/2025	3:15:00 AM	0.08
11/12/2025	3:30:00 AM	0.08
11/12/2025	3:45:00 AM	0.08
11/12/2025	4:00:00 AM	0.08
11/12/2025	4:15:00 AM	0.08
11/12/2025	4:30:00 AM	0.08
11/12/2025	4:45:00 AM	0.08
11/12/2025	5:00:00 AM	0.08
11/12/2025	5:15:00 AM	0.08
11/12/2025	5:30:00 AM	0.08
11/12/2025	5:45:00 AM	0.08
11/12/2025	6:00:00 AM	0.08
11/12/2025	6:15:00 AM	0.08
11/12/2025	6:30:00 AM	0.08
11/12/2025	6:45:00 AM	0.08
11/12/2025	7:00:00 AM	0.08
11/12/2025	7:15:00 AM	0.08
11/12/2025	7:30:00 AM	0.08
11/12/2025	7:45:00 AM	0.08
11/12/2025	8:00:00 AM	0.08
11/12/2025	8:15:00 AM	0.08
11/12/2025	8:30:00 AM	0.08
11/12/2025	8:45:00 AM	0.08
11/12/2025	9:00:00 AM	0.08
11/12/2025	9:15:00 AM	0.08
11/12/2025	9:30:00 AM	0.08
11/12/2025	9:45:00 AM	0.08
11/12/2025	10:00:00 AM	0.08
11/12/2025	10:15:00 AM	0.08
11/12/2025	10:30:00 AM	0.08
11/12/2025	10:45:00 AM	0.08
11/12/2025	11:00:00 AM	0.08
11/12/2025	11:15:00 AM	0.08
11/12/2025	11:30:00 AM	0.08
11/12/2025	11:45:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/12/2025	12:00:00 PM	0.08
11/12/2025	12:15:00 PM	0.08
11/12/2025	12:30:00 PM	0.08
11/12/2025	12:45:00 PM	0.08
11/12/2025	1:00:00 PM	0.08
11/12/2025	1:15:00 PM	0.08
11/12/2025	1:30:00 PM	0.08
11/12/2025	1:45:00 PM	0.08
11/12/2025	2:00:00 PM	0.08
11/12/2025	2:15:00 PM	0.08
11/12/2025	2:30:00 PM	0.08
11/12/2025	2:45:00 PM	0.08
11/12/2025	3:00:00 PM	0.08
11/12/2025	3:15:00 PM	0.08
11/12/2025	3:30:00 PM	0.08
11/12/2025	3:45:00 PM	0.08
11/12/2025	4:00:00 PM	0.08
11/12/2025	4:15:00 PM	0.08
11/12/2025	4:30:00 PM	0.08
11/12/2025	4:45:00 PM	0.08
11/12/2025	5:00:00 PM	0.08
11/12/2025	5:15:00 PM	0.08
11/12/2025	5:30:00 PM	0.08
11/12/2025	5:45:00 PM	0.08
11/12/2025	6:00:00 PM	0.08
11/12/2025	6:15:00 PM	0.08
11/12/2025	6:30:00 PM	0.08
11/12/2025	6:45:00 PM	0.08
11/12/2025	7:00:00 PM	0.08
11/12/2025	7:15:00 PM	0.08
11/12/2025	7:30:00 PM	0.08
11/12/2025	7:45:00 PM	0.08
11/12/2025	8:00:00 PM	0.08
11/12/2025	8:15:00 PM	0.08
11/12/2025	8:30:00 PM	0.08
11/12/2025	8:45:00 PM	0.08
11/12/2025	9:00:00 PM	0.08
11/12/2025	9:15:00 PM	0.08
11/12/2025	9:30:00 PM	0.08
11/12/2025	9:45:00 PM	0.08
11/12/2025	10:00:00 PM	0.08
11/12/2025	10:15:00 PM	0.08
11/12/2025	10:30:00 PM	0.08
11/12/2025	10:45:00 PM	0.08
11/12/2025	11:00:00 PM	0.08
11/12/2025	11:15:00 PM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/12/2025	11:30:00 PM	0.08
11/12/2025	11:45:00 PM	0.08
11/13/2025	12:00:00 AM	0.08
11/13/2025	12:15:00 AM	0.08
11/13/2025	12:30:00 AM	0.08
11/13/2025	12:45:00 AM	0.08
11/13/2025	1:00:00 AM	0.08
11/13/2025	1:15:00 AM	0.08
11/13/2025	1:30:00 AM	0.08
11/13/2025	1:45:00 AM	0.08
11/13/2025	2:00:00 AM	0.08
11/13/2025	2:15:00 AM	0.08
11/13/2025	2:30:00 AM	0.08
11/13/2025	2:45:00 AM	0.08
11/13/2025	3:00:00 AM	0.08
11/13/2025	3:15:00 AM	0.08
11/13/2025	3:30:00 AM	0.08
11/13/2025	3:45:00 AM	0.08
11/13/2025	4:00:00 AM	0.08
11/13/2025	4:15:00 AM	0.08
11/13/2025	4:30:00 AM	0.08
11/13/2025	4:45:00 AM	0.08
11/13/2025	5:00:00 AM	0.08
11/13/2025	5:15:00 AM	0.08
11/13/2025	5:30:00 AM	0.08
11/13/2025	5:45:00 AM	0.08
11/13/2025	6:00:00 AM	0.08
11/13/2025	6:15:00 AM	0.08
11/13/2025	6:30:00 AM	0.08
11/13/2025	6:45:00 AM	0.08
11/13/2025	7:00:00 AM	0.08
11/13/2025	7:15:00 AM	0.07
11/13/2025	7:30:00 AM	0.07
11/13/2025	7:45:00 AM	0.07
11/13/2025	8:00:00 AM	0.07
11/13/2025	8:15:00 AM	0.07
11/13/2025	8:30:00 AM	0.07
11/13/2025	8:45:00 AM	0.07
11/13/2025	9:00:00 AM	0.07
11/13/2025	9:15:00 AM	0.07
11/13/2025	9:30:00 AM	0.07
11/13/2025	9:45:00 AM	0.07
11/13/2025	10:00:00 AM	0.07
11/13/2025	10:15:00 AM	0.07
11/13/2025	10:30:00 AM	0.07
11/13/2025	10:45:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
11/13/2025	11:00:00 AM	0.07
11/13/2025	11:15:00 AM	0.07
11/13/2025	11:30:00 AM	0.07
11/13/2025	11:45:00 AM	0.07
11/13/2025	12:00:00 PM	0.07
11/13/2025	12:15:00 PM	0.07
11/13/2025	12:30:00 PM	0.07
11/13/2025	12:45:00 PM	0.07
11/13/2025	1:00:00 PM	0.08
11/13/2025	1:15:00 PM	0.08
11/13/2025	1:30:00 PM	0.08
11/13/2025	1:45:00 PM	0.08
11/13/2025	2:00:00 PM	0.08
11/13/2025	2:15:00 PM	0.08
11/13/2025	2:30:00 PM	0.08
11/13/2025	2:45:00 PM	0.08
11/13/2025	3:00:00 PM	0.08
11/13/2025	3:15:00 PM	0.08
11/13/2025	3:30:00 PM	0.08
11/13/2025	3:45:00 PM	0.08
11/13/2025	4:00:00 PM	0.08
11/13/2025	4:15:00 PM	0.08
11/13/2025	4:30:00 PM	0.08
11/13/2025	4:45:00 PM	0.08
11/13/2025	5:00:00 PM	0.08
11/13/2025	5:15:00 PM	0.08
11/13/2025	5:30:00 PM	0.08
11/13/2025	5:45:00 PM	0.08
11/13/2025	6:00:00 PM	0.08
11/13/2025	6:15:00 PM	0.08
11/13/2025	6:30:00 PM	0.08
11/13/2025	6:45:00 PM	0.08
11/13/2025	7:00:00 PM	0.08
11/13/2025	7:15:00 PM	0.08
11/13/2025	7:30:00 PM	0.08
11/13/2025	7:45:00 PM	0.08
11/13/2025	8:00:00 PM	0.08
11/13/2025	8:15:00 PM	0.08
11/13/2025	8:30:00 PM	0.08
11/13/2025	8:45:00 PM	0.08
11/13/2025	9:00:00 PM	0.08
11/13/2025	9:15:00 PM	0.08
11/13/2025	9:30:00 PM	0.08
11/13/2025	9:45:00 PM	0.08
11/13/2025	10:00:00 PM	0.08
11/13/2025	10:15:00 PM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/13/2025	10:30:00 PM	0.08
11/13/2025	10:45:00 PM	0.08
11/13/2025	11:00:00 PM	0.08
11/13/2025	11:15:00 PM	0.08
11/13/2025	11:30:00 PM	0.08
11/13/2025	11:45:00 PM	0.08
11/14/2025	12:00:00 AM	0.08
11/14/2025	12:15:00 AM	0.08
11/14/2025	12:30:00 AM	0.08
11/14/2025	12:45:00 AM	0.08
11/14/2025	1:00:00 AM	0.08
11/14/2025	1:15:00 AM	0.08
11/14/2025	1:30:00 AM	0.08
11/14/2025	1:45:00 AM	0.08
11/14/2025	2:00:00 AM	0.08
11/14/2025	2:15:00 AM	0.08
11/14/2025	2:30:00 AM	0.08
11/14/2025	2:45:00 AM	0.08
11/14/2025	3:00:00 AM	0.08
11/14/2025	3:15:00 AM	0.08
11/14/2025	3:30:00 AM	0.08
11/14/2025	3:45:00 AM	0.08
11/14/2025	4:00:00 AM	0.08
11/14/2025	4:15:00 AM	0.08
11/14/2025	4:30:00 AM	0.08
11/14/2025	4:45:00 AM	0.08
11/14/2025	5:00:00 AM	0.08
11/14/2025	5:15:00 AM	0.08
11/14/2025	5:30:00 AM	0.08
11/14/2025	5:45:00 AM	0.08
11/14/2025	6:00:00 AM	0.08
11/14/2025	6:15:00 AM	0.08
11/14/2025	6:30:00 AM	0.08
11/14/2025	6:45:00 AM	0.08
11/14/2025	7:00:00 AM	0.08
11/14/2025	7:15:00 AM	0.08
11/14/2025	7:30:00 AM	0.07
11/14/2025	7:45:00 AM	0.08
11/14/2025	8:00:00 AM	0.08
11/14/2025	8:15:00 AM	0.08
11/14/2025	8:30:00 AM	0.07
11/14/2025	8:45:00 AM	0.07
11/14/2025	9:00:00 AM	0.07
11/14/2025	9:15:00 AM	0.07
11/14/2025	9:30:00 AM	0.07
11/14/2025	9:45:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
11/14/2025	10:00:00 AM	0.07
11/14/2025	10:15:00 AM	0.07
11/14/2025	10:30:00 AM	0.07
11/14/2025	10:45:00 AM	0.07
11/14/2025	11:00:00 AM	0.07
11/14/2025	11:15:00 AM	0.07
11/14/2025	11:30:00 AM	0.07
11/14/2025	11:45:00 AM	0.07
11/14/2025	12:00:00 PM	0.07
11/14/2025	12:15:00 PM	0.07
11/14/2025	12:30:00 PM	0.07
11/14/2025	12:45:00 PM	0.07
11/14/2025	1:00:00 PM	0.07
11/14/2025	1:15:00 PM	0.07
11/14/2025	1:30:00 PM	0.07
11/14/2025	1:45:00 PM	0.07
11/14/2025	2:00:00 PM	0.07
11/14/2025	2:15:00 PM	0.07
11/14/2025	2:30:00 PM	0.07
11/14/2025	2:45:00 PM	0.07
11/14/2025	3:00:00 PM	0.07
11/14/2025	3:15:00 PM	0.06
11/14/2025	3:30:00 PM	0.06
11/14/2025	3:45:00 PM	0.06
11/14/2025	4:00:00 PM	0.06
11/14/2025	4:15:00 PM	0.06
11/14/2025	4:30:00 PM	0.06
11/14/2025	4:45:00 PM	0.06
11/14/2025	5:00:00 PM	0.06
11/14/2025	5:15:00 PM	0.06
11/14/2025	5:30:00 PM	0.06
11/14/2025	5:45:00 PM	0.06
11/14/2025	6:00:00 PM	0.06
11/14/2025	6:15:00 PM	0.06
11/14/2025	6:30:00 PM	0.06
11/14/2025	6:45:00 PM	0.06
11/14/2025	7:00:00 PM	0.06
11/14/2025	7:15:00 PM	0.06
11/14/2025	7:30:00 PM	0.06
11/14/2025	7:45:00 PM	0.06
11/14/2025	8:00:00 PM	0.06
11/14/2025	8:15:00 PM	0.06
11/14/2025	8:30:00 PM	0.06
11/14/2025	8:45:00 PM	0.06
11/14/2025	9:00:00 PM	0.06
11/14/2025	9:15:00 PM	0.06

Georges Ditch Return Gage

DATE	TIME	GAGE
11/14/2025	9:30:00 PM	0.06
11/14/2025	9:45:00 PM	0.06
11/14/2025	10:00:00 PM	0.06
11/14/2025	10:15:00 PM	0.06
11/14/2025	10:30:00 PM	0.06
11/14/2025	10:45:00 PM	0.06
11/14/2025	11:00:00 PM	0.06
11/14/2025	11:15:00 PM	0.06
11/14/2025	11:30:00 PM	0.06
11/14/2025	11:45:00 PM	0.06
11/15/2025	12:00:00 AM	0.06
11/15/2025	12:15:00 AM	0.06
11/15/2025	12:30:00 AM	0.06
11/15/2025	12:45:00 AM	0.06
11/15/2025	1:00:00 AM	0.07
11/15/2025	1:15:00 AM	0.07
11/15/2025	1:30:00 AM	0.08
11/15/2025	1:45:00 AM	0.08
11/15/2025	2:00:00 AM	0.08
11/15/2025	2:15:00 AM	0.09
11/15/2025	2:30:00 AM	0.09
11/15/2025	2:45:00 AM	0.09
11/15/2025	3:00:00 AM	0.09
11/15/2025	3:15:00 AM	0.09
11/15/2025	3:30:00 AM	0.09
11/15/2025	3:45:00 AM	0.09
11/15/2025	4:00:00 AM	0.09
11/15/2025	4:15:00 AM	0.09
11/15/2025	4:30:00 AM	0.09
11/15/2025	4:45:00 AM	0.09
11/15/2025	5:00:00 AM	0.09
11/15/2025	5:15:00 AM	0.09
11/15/2025	5:30:00 AM	0.09
11/15/2025	5:45:00 AM	0.09
11/15/2025	6:00:00 AM	0.09
11/15/2025	6:15:00 AM	0.09
11/15/2025	6:30:00 AM	0.09
11/15/2025	6:45:00 AM	0.09
11/15/2025	7:00:00 AM	0.09
11/15/2025	7:15:00 AM	0.09
11/15/2025	7:30:00 AM	0.09
11/15/2025	7:45:00 AM	0.09
11/15/2025	8:00:00 AM	0.09
11/15/2025	8:15:00 AM	0.09
11/15/2025	8:30:00 AM	0.09
11/15/2025	8:45:00 AM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
11/15/2025	9:00:00 AM	0.09
11/15/2025	9:15:00 AM	0.09
11/15/2025	9:30:00 AM	0.09
11/15/2025	9:45:00 AM	0.09
11/15/2025	10:00:00 AM	0.09
11/15/2025	10:15:00 AM	0.09
11/15/2025	10:30:00 AM	0.09
11/15/2025	10:45:00 AM	0.09
11/15/2025	11:00:00 AM	0.09
11/15/2025	11:15:00 AM	0.09
11/15/2025	11:30:00 AM	0.09
11/15/2025	11:45:00 AM	0.09
11/15/2025	12:00:00 PM	0.09
11/15/2025	12:15:00 PM	0.09
11/15/2025	12:30:00 PM	0.09
11/15/2025	12:45:00 PM	0.1
11/15/2025	1:00:00 PM	0.1
11/15/2025	1:15:00 PM	0.09
11/15/2025	1:30:00 PM	0.1
11/15/2025	1:45:00 PM	0.1
11/15/2025	2:00:00 PM	0.1
11/15/2025	2:15:00 PM	0.1
11/15/2025	2:30:00 PM	0.1
11/15/2025	2:45:00 PM	0.1
11/15/2025	3:00:00 PM	0.1
11/15/2025	3:15:00 PM	0.11
11/15/2025	3:30:00 PM	0.11
11/15/2025	3:45:00 PM	0.11
11/15/2025	4:00:00 PM	0.11
11/15/2025	4:15:00 PM	0.11
11/15/2025	4:30:00 PM	0.11
11/15/2025	4:45:00 PM	0.11
11/15/2025	5:00:00 PM	0.11
11/15/2025	5:15:00 PM	0.11
11/15/2025	5:30:00 PM	0.11
11/15/2025	5:45:00 PM	0.11
11/15/2025	6:00:00 PM	0.11
11/15/2025	6:15:00 PM	0.11
11/15/2025	6:30:00 PM	0.11
11/15/2025	6:45:00 PM	0.11
11/15/2025	7:00:00 PM	0.11
11/15/2025	7:15:00 PM	0.11
11/15/2025	7:30:00 PM	0.11
11/15/2025	7:45:00 PM	0.11
11/15/2025	8:00:00 PM	0.11
11/15/2025	8:15:00 PM	0.11

Georges Ditch Return Gage

DATE	TIME	GAGE
11/15/2025	8:30:00 PM	0.11
11/15/2025	8:45:00 PM	0.11
11/15/2025	9:00:00 PM	0.11
11/15/2025	9:15:00 PM	0.11
11/15/2025	9:30:00 PM	0.11
11/15/2025	9:45:00 PM	0.11
11/15/2025	10:00:00 PM	0.11
11/15/2025	10:15:00 PM	0.11
11/15/2025	10:30:00 PM	0.11
11/15/2025	10:45:00 PM	0.11
11/15/2025	11:00:00 PM	0.11
11/15/2025	11:15:00 PM	0.11
11/15/2025	11:30:00 PM	0.11
11/15/2025	11:45:00 PM	0.11
11/16/2025	12:00:00 AM	0.11
11/16/2025	12:15:00 AM	0.11
11/16/2025	12:30:00 AM	0.11
11/16/2025	12:45:00 AM	0.11
11/16/2025	1:00:00 AM	0.11
11/16/2025	1:15:00 AM	0.11
11/16/2025	1:30:00 AM	0.11
11/16/2025	1:45:00 AM	0.11
11/16/2025	2:00:00 AM	0.11
11/16/2025	2:15:00 AM	0.11
11/16/2025	2:30:00 AM	0.11
11/16/2025	2:45:00 AM	0.11
11/16/2025	3:00:00 AM	0.11
11/16/2025	3:15:00 AM	0.11
11/16/2025	3:30:00 AM	0.11
11/16/2025	3:45:00 AM	0.11
11/16/2025	4:00:00 AM	0.11
11/16/2025	4:15:00 AM	0.11
11/16/2025	4:30:00 AM	0.11
11/16/2025	4:45:00 AM	0.11
11/16/2025	5:00:00 AM	0.11
11/16/2025	5:15:00 AM	0.1
11/16/2025	5:30:00 AM	0.1
11/16/2025	5:45:00 AM	0.1
11/16/2025	6:00:00 AM	0.1
11/16/2025	6:15:00 AM	0.1
11/16/2025	6:30:00 AM	0.1
11/16/2025	6:45:00 AM	0.1
11/16/2025	7:00:00 AM	0.1
11/16/2025	7:15:00 AM	0.1
11/16/2025	7:30:00 AM	0.1
11/16/2025	7:45:00 AM	0.1

Georges Ditch Return Gage

DATE	TIME	GAGE
11/16/2025	8:00:00 AM	0.1
11/16/2025	8:15:00 AM	0.09
11/16/2025	8:30:00 AM	0.09
11/16/2025	8:45:00 AM	0.09
11/16/2025	9:00:00 AM	0.09
11/16/2025	9:15:00 AM	0.09
11/16/2025	9:30:00 AM	0.09
11/16/2025	9:45:00 AM	0.09
11/16/2025	10:00:00 AM	0.09
11/16/2025	10:15:00 AM	0.09
11/16/2025	10:30:00 AM	0.09
11/16/2025	10:45:00 AM	0.09
11/16/2025	11:00:00 AM	0.09
11/16/2025	11:15:00 AM	0.09
11/16/2025	11:30:00 AM	0.09
11/16/2025	11:45:00 AM	0.09
11/16/2025	12:00:00 PM	0.08
11/16/2025	12:15:00 PM	0.08
11/16/2025	12:30:00 PM	0.08
11/16/2025	12:45:00 PM	0.08
11/16/2025	1:00:00 PM	0.08
11/16/2025	1:15:00 PM	0.08
11/16/2025	1:30:00 PM	0.08
11/16/2025	1:45:00 PM	0.08
11/16/2025	2:00:00 PM	0.08
11/16/2025	2:15:00 PM	0.08
11/16/2025	2:30:00 PM	0.08
11/16/2025	2:45:00 PM	0.08
11/16/2025	3:00:00 PM	0.08
11/16/2025	3:15:00 PM	0.08
11/16/2025	3:30:00 PM	0.08
11/16/2025	3:45:00 PM	0.08
11/16/2025	4:00:00 PM	0.08
11/16/2025	4:15:00 PM	0.08
11/16/2025	4:30:00 PM	0.08
11/16/2025	4:45:00 PM	0.08
11/16/2025	5:00:00 PM	0.08
11/16/2025	5:15:00 PM	0.08
11/16/2025	5:30:00 PM	0.08
11/16/2025	5:45:00 PM	0.08
11/16/2025	6:00:00 PM	0.08
11/16/2025	6:15:00 PM	0.08
11/16/2025	6:30:00 PM	0.08
11/16/2025	6:45:00 PM	0.08
11/16/2025	7:00:00 PM	0.08
11/16/2025	7:15:00 PM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/16/2025	7:30:00 PM	0.08
11/16/2025	7:45:00 PM	0.08
11/16/2025	8:00:00 PM	0.08
11/16/2025	8:15:00 PM	0.08
11/16/2025	8:30:00 PM	0.09
11/16/2025	8:45:00 PM	0.09
11/16/2025	9:00:00 PM	0.09
11/16/2025	9:15:00 PM	0.09
11/16/2025	9:30:00 PM	0.09
11/16/2025	9:45:00 PM	0.09
11/16/2025	10:00:00 PM	0.09
11/16/2025	10:15:00 PM	0.09
11/16/2025	10:30:00 PM	0.09
11/16/2025	10:45:00 PM	0.09
11/16/2025	11:00:00 PM	0.09
11/16/2025	11:15:00 PM	0.09
11/16/2025	11:30:00 PM	0.09
11/16/2025	11:45:00 PM	0.09
11/17/2025	12:00:00 AM	0.09
11/17/2025	12:15:00 AM	0.09
11/17/2025	12:30:00 AM	0.09
11/17/2025	12:45:00 AM	0.09
11/17/2025	1:00:00 AM	0.09
11/17/2025	1:15:00 AM	0.09
11/17/2025	1:30:00 AM	0.09
11/17/2025	1:45:00 AM	0.09
11/17/2025	2:00:00 AM	0.09
11/17/2025	2:15:00 AM	0.09
11/17/2025	2:30:00 AM	0.09
11/17/2025	2:45:00 AM	0.09
11/17/2025	3:00:00 AM	0.09
11/17/2025	3:15:00 AM	0.09
11/17/2025	3:30:00 AM	0.09
11/17/2025	3:45:00 AM	0.09
11/17/2025	4:00:00 AM	0.09
11/17/2025	4:15:00 AM	0.09
11/17/2025	4:30:00 AM	0.09
11/17/2025	4:45:00 AM	0.09
11/17/2025	5:00:00 AM	0.09
11/17/2025	5:15:00 AM	0.09
11/17/2025	5:30:00 AM	0.09
11/17/2025	5:45:00 AM	0.09
11/17/2025	6:00:00 AM	0.09
11/17/2025	6:15:00 AM	0.09
11/17/2025	6:30:00 AM	0.09
11/17/2025	6:45:00 AM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
11/17/2025	7:00:00 AM	0.09
11/17/2025	7:15:00 AM	0.09
11/17/2025	7:30:00 AM	0.09
11/17/2025	7:45:00 AM	0.09
11/17/2025	8:00:00 AM	0.09
11/17/2025	8:15:00 AM	0.09
11/17/2025	8:30:00 AM	0.09
11/17/2025	8:45:00 AM	0.09
11/17/2025	9:00:00 AM	0.09
11/17/2025	9:15:00 AM	0.09
11/17/2025	9:30:00 AM	0.09
11/17/2025	9:45:00 AM	0.09
11/17/2025	10:00:00 AM	0.09
11/17/2025	10:15:00 AM	0.09
11/17/2025	10:30:00 AM	0.09
11/17/2025	10:45:00 AM	0.09
11/17/2025	11:00:00 AM	0.09
11/17/2025	11:15:00 AM	0.09
11/17/2025	11:30:00 AM	0.09
11/17/2025	11:45:00 AM	0.09
11/17/2025	12:00:00 PM	0.09
11/17/2025	12:15:00 PM	0.09
11/17/2025	12:30:00 PM	0.09
11/17/2025	12:45:00 PM	0.09
11/17/2025	1:00:00 PM	0.09
11/17/2025	1:15:00 PM	0.09
11/17/2025	1:30:00 PM	0.09
11/17/2025	1:45:00 PM	0.09
11/17/2025	2:00:00 PM	0.09
11/17/2025	2:15:00 PM	0.08
11/17/2025	2:30:00 PM	0.08
11/17/2025	2:45:00 PM	0.08
11/17/2025	3:00:00 PM	0.08
11/17/2025	3:15:00 PM	0.08
11/17/2025	3:30:00 PM	0.08
11/17/2025	3:45:00 PM	0.08
11/17/2025	4:00:00 PM	0.08
11/17/2025	4:15:00 PM	0.08
11/17/2025	4:30:00 PM	0.08
11/17/2025	4:45:00 PM	0.08
11/17/2025	5:00:00 PM	0.08
11/17/2025	5:15:00 PM	0.08
11/17/2025	5:30:00 PM	0.08
11/17/2025	5:45:00 PM	0.08
11/17/2025	6:00:00 PM	0.08
11/17/2025	6:15:00 PM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/17/2025	6:30:00 PM	0.08
11/17/2025	6:45:00 PM	0.08
11/17/2025	7:00:00 PM	0.08
11/17/2025	7:15:00 PM	0.08
11/17/2025	7:30:00 PM	0.08
11/17/2025	7:45:00 PM	0.08
11/17/2025	8:00:00 PM	0.08
11/17/2025	8:15:00 PM	0.08
11/17/2025	8:30:00 PM	0.08
11/17/2025	8:45:00 PM	0.08
11/17/2025	9:00:00 PM	0.08
11/17/2025	9:15:00 PM	0.08
11/17/2025	9:30:00 PM	0.08
11/17/2025	9:45:00 PM	0.08
11/17/2025	10:00:00 PM	0.08
11/17/2025	10:15:00 PM	0.08
11/17/2025	10:30:00 PM	0.08
11/17/2025	10:45:00 PM	0.08
11/17/2025	11:00:00 PM	0.08
11/17/2025	11:15:00 PM	0.08
11/17/2025	11:30:00 PM	0.08
11/17/2025	11:45:00 PM	0.08
11/18/2025	12:00:00 AM	0.08
11/18/2025	12:15:00 AM	0.08
11/18/2025	12:30:00 AM	0.08
11/18/2025	12:45:00 AM	0.08
11/18/2025	1:00:00 AM	0.08
11/18/2025	1:15:00 AM	0.08
11/18/2025	1:30:00 AM	0.08
11/18/2025	1:45:00 AM	0.08
11/18/2025	2:00:00 AM	0.08
11/18/2025	2:15:00 AM	0.08
11/18/2025	2:30:00 AM	0.08
11/18/2025	2:45:00 AM	0.08
11/18/2025	3:00:00 AM	0.08
11/18/2025	3:15:00 AM	0.08
11/18/2025	3:30:00 AM	0.08
11/18/2025	3:45:00 AM	0.08
11/18/2025	4:00:00 AM	0.08
11/18/2025	4:15:00 AM	0.08
11/18/2025	4:30:00 AM	0.08
11/18/2025	4:45:00 AM	0.08
11/18/2025	5:00:00 AM	0.08
11/18/2025	5:15:00 AM	0.08
11/18/2025	5:30:00 AM	0.08
11/18/2025	5:45:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/18/2025	6:00:00 AM	0.08
11/18/2025	6:15:00 AM	0.08
11/18/2025	6:30:00 AM	0.08
11/18/2025	6:45:00 AM	0.08
11/18/2025	7:00:00 AM	0.08
11/18/2025	7:15:00 AM	0.08
11/18/2025	7:30:00 AM	0.08
11/18/2025	7:45:00 AM	0.08
11/18/2025	8:00:00 AM	0.08
11/18/2025	8:15:00 AM	0.08
11/18/2025	8:30:00 AM	0.08
11/18/2025	8:45:00 AM	0.08
11/18/2025	9:00:00 AM	0.08
11/18/2025	9:15:00 AM	0.08
11/18/2025	9:30:00 AM	0.08
11/18/2025	9:45:00 AM	0.08
11/18/2025	10:00:00 AM	0.08
11/18/2025	10:15:00 AM	0.08
11/18/2025	10:30:00 AM	0.08
11/18/2025	10:45:00 AM	0.08
11/18/2025	11:00:00 AM	0.08
11/18/2025	11:15:00 AM	0.08
11/18/2025	11:30:00 AM	0.08
11/18/2025	11:45:00 AM	0.08
11/18/2025	12:00:00 PM	0.08
11/18/2025	12:15:00 PM	0.08
11/18/2025	12:30:00 PM	0.08
11/18/2025	12:45:00 PM	0.08
11/18/2025	1:00:00 PM	0.08
11/18/2025	1:15:00 PM	0.08
11/18/2025	1:30:00 PM	0.07
11/18/2025	1:45:00 PM	0.07
11/18/2025	2:00:00 PM	0.07
11/18/2025	2:15:00 PM	0.07
11/18/2025	2:30:00 PM	0.08
11/18/2025	2:45:00 PM	0.07
11/18/2025	3:00:00 PM	0.07
11/18/2025	3:15:00 PM	0.07
11/18/2025	3:30:00 PM	0.07
11/18/2025	3:45:00 PM	0.07
11/18/2025	4:00:00 PM	0.07
11/18/2025	4:15:00 PM	0.07
11/18/2025	4:30:00 PM	0.07
11/18/2025	4:45:00 PM	0.07
11/18/2025	5:00:00 PM	0.07
11/18/2025	5:15:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
11/18/2025	5:30:00 PM	0.07
11/18/2025	5:45:00 PM	0.07
11/18/2025	6:00:00 PM	0.07
11/18/2025	6:15:00 PM	0.07
11/18/2025	6:30:00 PM	0.07
11/18/2025	6:45:00 PM	0.07
11/18/2025	7:00:00 PM	0.07
11/18/2025	7:15:00 PM	0.07
11/18/2025	7:30:00 PM	0.07
11/18/2025	7:45:00 PM	0.07
11/18/2025	8:00:00 PM	0.07
11/18/2025	8:15:00 PM	0.07
11/18/2025	8:30:00 PM	0.07
11/18/2025	8:45:00 PM	0.07
11/18/2025	9:00:00 PM	0.07
11/18/2025	9:15:00 PM	0.07
11/18/2025	9:30:00 PM	0.08
11/18/2025	9:45:00 PM	0.08
11/18/2025	10:00:00 PM	0.08
11/18/2025	10:15:00 PM	0.08
11/18/2025	10:30:00 PM	0.08
11/18/2025	10:45:00 PM	0.08
11/18/2025	11:00:00 PM	0.08
11/18/2025	11:15:00 PM	0.08
11/18/2025	11:30:00 PM	0.08
11/18/2025	11:45:00 PM	0.08
11/19/2025	12:00:00 AM	0.08
11/19/2025	12:15:00 AM	0.08
11/19/2025	12:30:00 AM	0.08
11/19/2025	12:45:00 AM	0.08
11/19/2025	1:00:00 AM	0.08
11/19/2025	1:15:00 AM	0.08
11/19/2025	1:30:00 AM	0.08
11/19/2025	1:45:00 AM	0.08
11/19/2025	2:00:00 AM	0.08
11/19/2025	2:15:00 AM	0.08
11/19/2025	2:30:00 AM	0.08
11/19/2025	2:45:00 AM	0.08
11/19/2025	3:00:00 AM	0.08
11/19/2025	3:15:00 AM	0.08
11/19/2025	3:30:00 AM	0.08
11/19/2025	3:45:00 AM	0.08
11/19/2025	4:00:00 AM	0.08
11/19/2025	4:15:00 AM	0.08
11/19/2025	4:30:00 AM	0.09
11/19/2025	4:45:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/19/2025	5:00:00 AM	0.08
11/19/2025	5:15:00 AM	0.09
11/19/2025	5:30:00 AM	0.09
11/19/2025	5:45:00 AM	0.09
11/19/2025	6:00:00 AM	0.09
11/19/2025	6:15:00 AM	0.09
11/19/2025	6:30:00 AM	0.09
11/19/2025	6:45:00 AM	0.09
11/19/2025	7:00:00 AM	0.09
11/19/2025	7:15:00 AM	0.09
11/19/2025	7:30:00 AM	0.09
11/19/2025	7:45:00 AM	0.09
11/19/2025	8:00:00 AM	0.09
11/19/2025	8:15:00 AM	0.09
11/19/2025	8:30:00 AM	0.09
11/19/2025	8:45:00 AM	0.09
11/19/2025	9:00:00 AM	0.09
11/19/2025	9:15:00 AM	0.09
11/19/2025	9:30:00 AM	0.09
11/19/2025	9:45:00 AM	0.09
11/19/2025	10:00:00 AM	0.09
11/19/2025	10:15:00 AM	0.09
11/19/2025	10:30:00 AM	0.09
11/19/2025	10:45:00 AM	0.09
11/19/2025	11:00:00 AM	0.09
11/19/2025	11:15:00 AM	0.09
11/19/2025	11:30:00 AM	0.09
11/19/2025	11:45:00 AM	0.09
11/19/2025	12:00:00 PM	0.09
11/19/2025	12:15:00 PM	0.09
11/19/2025	12:30:00 PM	0.09
11/19/2025	12:45:00 PM	0.09
11/19/2025	1:00:00 PM	0.09
11/19/2025	1:15:00 PM	0.09
11/19/2025	1:30:00 PM	0.09
11/19/2025	1:45:00 PM	0.09
11/19/2025	2:00:00 PM	0.09
11/19/2025	2:15:00 PM	0.09
11/19/2025	2:30:00 PM	0.09
11/19/2025	2:45:00 PM	0.09
11/19/2025	3:00:00 PM	0.09
11/19/2025	3:15:00 PM	0.09
11/19/2025	3:30:00 PM	0.09
11/19/2025	3:45:00 PM	0.09
11/19/2025	4:00:00 PM	0.09
11/19/2025	4:15:00 PM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
11/19/2025	4:30:00 PM	0.09
11/19/2025	4:45:00 PM	0.09
11/19/2025	5:00:00 PM	0.09
11/19/2025	5:15:00 PM	0.09
11/19/2025	5:30:00 PM	0.09
11/19/2025	5:45:00 PM	0.09
11/19/2025	6:00:00 PM	0.09
11/19/2025	6:15:00 PM	0.09
11/19/2025	6:30:00 PM	0.09
11/19/2025	6:45:00 PM	0.09
11/19/2025	7:00:00 PM	0.09
11/19/2025	7:15:00 PM	0.09
11/19/2025	7:30:00 PM	0.09
11/19/2025	7:45:00 PM	0.09
11/19/2025	8:00:00 PM	0.09
11/19/2025	8:15:00 PM	0.09
11/19/2025	8:30:00 PM	0.09
11/19/2025	8:45:00 PM	0.09
11/19/2025	9:00:00 PM	0.09
11/19/2025	9:15:00 PM	0.09
11/19/2025	9:30:00 PM	0.09
11/19/2025	9:45:00 PM	0.09
11/19/2025	10:00:00 PM	0.09
11/19/2025	10:15:00 PM	0.09
11/19/2025	10:30:00 PM	0.09
11/19/2025	10:45:00 PM	0.09
11/19/2025	11:00:00 PM	0.09
11/19/2025	11:15:00 PM	0.09
11/19/2025	11:30:00 PM	0.09
11/19/2025	11:45:00 PM	0.09
11/20/2025	12:00:00 AM	0.09
11/20/2025	12:15:00 AM	0.09
11/20/2025	12:30:00 AM	0.09
11/20/2025	12:45:00 AM	0.09
11/20/2025	1:00:00 AM	0.09
11/20/2025	1:15:00 AM	0.09
11/20/2025	1:30:00 AM	0.09
11/20/2025	1:45:00 AM	0.09
11/20/2025	2:00:00 AM	0.09
11/20/2025	2:15:00 AM	0.09
11/20/2025	2:30:00 AM	0.09
11/20/2025	2:45:00 AM	0.09
11/20/2025	3:00:00 AM	0.09
11/20/2025	3:15:00 AM	0.09
11/20/2025	3:30:00 AM	0.09
11/20/2025	3:45:00 AM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
11/20/2025	4:00:00 AM	0.09
11/20/2025	4:15:00 AM	0.09
11/20/2025	4:30:00 AM	0.09
11/20/2025	4:45:00 AM	0.09
11/20/2025	5:00:00 AM	0.09
11/20/2025	5:15:00 AM	0.09
11/20/2025	5:30:00 AM	0.09
11/20/2025	5:45:00 AM	0.09
11/20/2025	6:00:00 AM	0.09
11/20/2025	6:15:00 AM	0.09
11/20/2025	6:30:00 AM	0.09
11/20/2025	6:45:00 AM	0.09
11/20/2025	7:00:00 AM	0.09
11/20/2025	7:15:00 AM	0.09
11/20/2025	7:30:00 AM	0.08
11/20/2025	7:45:00 AM	0.09
11/20/2025	8:00:00 AM	0.09
11/20/2025	8:15:00 AM	0.09
11/20/2025	8:30:00 AM	0.09
11/20/2025	8:45:00 AM	0.08
11/20/2025	9:00:00 AM	0.08
11/20/2025	9:15:00 AM	0.08
11/20/2025	9:30:00 AM	0.08
11/20/2025	9:45:00 AM	0.08
11/20/2025	10:00:00 AM	0.08
11/20/2025	10:15:00 AM	0.08
11/20/2025	10:30:00 AM	0.08
11/20/2025	10:45:00 AM	0.08
11/20/2025	11:00:00 AM	0.08
11/20/2025	11:15:00 AM	0.08
11/20/2025	11:30:00 AM	0.08
11/20/2025	11:45:00 AM	0.08
11/20/2025	12:00:00 PM	0.08
11/20/2025	12:15:00 PM	0.08
11/20/2025	12:30:00 PM	0.08
11/20/2025	12:45:00 PM	0.08
11/20/2025	1:00:00 PM	0.08
11/20/2025	1:15:00 PM	0.08
11/20/2025	1:30:00 PM	0.08
11/20/2025	1:45:00 PM	0.08
11/20/2025	2:00:00 PM	0.08
11/20/2025	2:15:00 PM	0.08
11/20/2025	2:30:00 PM	0.08
11/20/2025	2:45:00 PM	0.08
11/20/2025	3:00:00 PM	0.08
11/20/2025	3:15:00 PM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/20/2025	3:30:00 PM	0.08
11/20/2025	3:45:00 PM	0.08
11/20/2025	4:00:00 PM	0.08
11/20/2025	4:15:00 PM	0.08
11/20/2025	4:30:00 PM	0.08
11/20/2025	4:45:00 PM	0.08
11/20/2025	5:00:00 PM	0.08
11/20/2025	5:15:00 PM	0.08
11/20/2025	5:30:00 PM	0.08
11/20/2025	5:45:00 PM	0.08
11/20/2025	6:00:00 PM	0.08
11/20/2025	6:15:00 PM	0.08
11/20/2025	6:30:00 PM	0.08
11/20/2025	6:45:00 PM	0.08
11/20/2025	7:00:00 PM	0.08
11/20/2025	7:15:00 PM	0.08
11/20/2025	7:30:00 PM	0.08
11/20/2025	7:45:00 PM	0.08
11/20/2025	8:00:00 PM	0.08
11/20/2025	8:15:00 PM	0.08
11/20/2025	8:30:00 PM	0.08
11/20/2025	8:45:00 PM	0.08
11/20/2025	9:00:00 PM	0.08
11/20/2025	9:15:00 PM	0.08
11/20/2025	9:30:00 PM	0.08
11/20/2025	9:45:00 PM	0.08
11/20/2025	10:00:00 PM	0.08
11/20/2025	10:15:00 PM	0.08
11/20/2025	10:30:00 PM	0.08
11/20/2025	10:45:00 PM	0.08
11/20/2025	11:00:00 PM	0.08
11/20/2025	11:15:00 PM	0.08
11/20/2025	11:30:00 PM	0.08
11/20/2025	11:45:00 PM	0.08
11/21/2025	12:00:00 AM	0.08
11/21/2025	12:15:00 AM	0.08
11/21/2025	12:30:00 AM	0.08
11/21/2025	12:45:00 AM	0.08
11/21/2025	1:00:00 AM	0.08
11/21/2025	1:15:00 AM	0.08
11/21/2025	1:30:00 AM	0.08
11/21/2025	1:45:00 AM	0.08
11/21/2025	2:00:00 AM	0.08
11/21/2025	2:15:00 AM	0.08
11/21/2025	2:30:00 AM	0.08
11/21/2025	2:45:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/21/2025	3:00:00 AM	0.08
11/21/2025	3:15:00 AM	0.08
11/21/2025	3:30:00 AM	0.08
11/21/2025	3:45:00 AM	0.08
11/21/2025	4:00:00 AM	0.08
11/21/2025	4:15:00 AM	0.08
11/21/2025	4:30:00 AM	0.08
11/21/2025	4:45:00 AM	0.08
11/21/2025	5:00:00 AM	0.08
11/21/2025	5:15:00 AM	0.08
11/21/2025	5:30:00 AM	0.08
11/21/2025	5:45:00 AM	0.08
11/21/2025	6:00:00 AM	0.08
11/21/2025	6:15:00 AM	0.08
11/21/2025	6:30:00 AM	0.08
11/21/2025	6:45:00 AM	0.08
11/21/2025	7:00:00 AM	0.08
11/21/2025	7:15:00 AM	0.08
11/21/2025	7:30:00 AM	0.08
11/21/2025	7:45:00 AM	0.08
11/21/2025	8:00:00 AM	0.08
11/21/2025	8:15:00 AM	0.08
11/21/2025	8:30:00 AM	0.08
11/21/2025	8:45:00 AM	0.08
11/21/2025	9:00:00 AM	0.08
11/21/2025	9:15:00 AM	0.08
11/21/2025	9:30:00 AM	0.08
11/21/2025	9:45:00 AM	0.08
11/21/2025	10:00:00 AM	0.08
11/21/2025	10:15:00 AM	0.08
11/21/2025	10:30:00 AM	0.08
11/21/2025	10:45:00 AM	0.08
11/21/2025	11:00:00 AM	0.08
11/21/2025	11:15:00 AM	0.08
11/21/2025	11:30:00 AM	0.08
11/21/2025	11:45:00 AM	0.08
11/21/2025	12:00:00 PM	0.08
11/21/2025	12:15:00 PM	0.08
11/21/2025	12:30:00 PM	0.08
11/21/2025	12:45:00 PM	0.08
11/21/2025	1:00:00 PM	0.08
11/21/2025	1:15:00 PM	0.08
11/21/2025	1:30:00 PM	0.08
11/21/2025	1:45:00 PM	0.08
11/21/2025	2:00:00 PM	0.08
11/21/2025	2:15:00 PM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/21/2025	2:30:00 PM	0.08
11/21/2025	2:45:00 PM	0.08
11/21/2025	3:00:00 PM	0.08
11/21/2025	3:15:00 PM	0.08
11/21/2025	3:30:00 PM	0.08
11/21/2025	3:45:00 PM	0.08
11/21/2025	4:00:00 PM	0.08
11/21/2025	4:15:00 PM	0.08
11/21/2025	4:30:00 PM	0.08
11/21/2025	4:45:00 PM	0.08
11/21/2025	5:00:00 PM	0.08
11/21/2025	5:15:00 PM	0.08
11/21/2025	5:30:00 PM	0.08
11/21/2025	5:45:00 PM	0.08
11/21/2025	6:00:00 PM	0.08
11/21/2025	6:15:00 PM	0.08
11/21/2025	6:30:00 PM	0.08
11/21/2025	6:45:00 PM	0.08
11/21/2025	7:00:00 PM	0.08
11/21/2025	7:15:00 PM	0.08
11/21/2025	7:30:00 PM	0.08
11/21/2025	7:45:00 PM	0.08
11/21/2025	8:00:00 PM	0.08
11/21/2025	8:15:00 PM	0.08
11/21/2025	8:30:00 PM	0.08
11/21/2025	8:45:00 PM	0.08
11/21/2025	9:00:00 PM	0.08
11/21/2025	9:15:00 PM	0.08
11/21/2025	9:30:00 PM	0.08
11/21/2025	9:45:00 PM	0.08
11/21/2025	10:00:00 PM	0.08
11/21/2025	10:15:00 PM	0.08
11/21/2025	10:30:00 PM	0.08
11/21/2025	10:45:00 PM	0.08
11/21/2025	11:00:00 PM	0.08
11/21/2025	11:15:00 PM	0.08
11/21/2025	11:30:00 PM	0.08
11/21/2025	11:45:00 PM	0.08
11/22/2025	12:00:00 AM	0.08
11/22/2025	12:15:00 AM	0.08
11/22/2025	12:30:00 AM	0.08
11/22/2025	12:45:00 AM	0.08
11/22/2025	1:00:00 AM	0.08
11/22/2025	1:15:00 AM	0.08
11/22/2025	1:30:00 AM	0.08
11/22/2025	1:45:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/22/2025	2:00:00 AM	0.08
11/22/2025	2:15:00 AM	0.08
11/22/2025	2:30:00 AM	0.08
11/22/2025	2:45:00 AM	0.08
11/22/2025	3:00:00 AM	0.08
11/22/2025	3:15:00 AM	0.08
11/22/2025	3:30:00 AM	0.08
11/22/2025	3:45:00 AM	0.08
11/22/2025	4:00:00 AM	0.08
11/22/2025	4:15:00 AM	0.08
11/22/2025	4:30:00 AM	0.08
11/22/2025	4:45:00 AM	0.08
11/22/2025	5:00:00 AM	0.08
11/22/2025	5:15:00 AM	0.08
11/22/2025	5:30:00 AM	0.08
11/22/2025	5:45:00 AM	0.08
11/22/2025	6:00:00 AM	0.08
11/22/2025	6:15:00 AM	0.08
11/22/2025	6:30:00 AM	0.08
11/22/2025	6:45:00 AM	0.08
11/22/2025	7:00:00 AM	0.08
11/22/2025	7:15:00 AM	0.08
11/22/2025	7:30:00 AM	0.08
11/22/2025	7:45:00 AM	0.08
11/22/2025	8:00:00 AM	0.08
11/22/2025	8:15:00 AM	0.08
11/22/2025	8:30:00 AM	0.08
11/22/2025	8:45:00 AM	0.08
11/22/2025	9:00:00 AM	0.08
11/22/2025	9:15:00 AM	0.08
11/22/2025	9:30:00 AM	0.08
11/22/2025	9:45:00 AM	0.08
11/22/2025	10:00:00 AM	0.08
11/22/2025	10:15:00 AM	0.08
11/22/2025	10:30:00 AM	0.08
11/22/2025	10:45:00 AM	0.08
11/22/2025	11:00:00 AM	0.08
11/22/2025	11:15:00 AM	0.08
11/22/2025	11:30:00 AM	0.08
11/22/2025	11:45:00 AM	0.08
11/22/2025	12:00:00 PM	0.08
11/22/2025	12:15:00 PM	0.08
11/22/2025	12:30:00 PM	0.08
11/22/2025	12:45:00 PM	0.08
11/22/2025	1:00:00 PM	0.08
11/22/2025	1:15:00 PM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/22/2025	1:30:00 PM	0.08
11/22/2025	1:45:00 PM	0.08
11/22/2025	2:00:00 PM	0.08
11/22/2025	2:15:00 PM	0.08
11/22/2025	2:30:00 PM	0.08
11/22/2025	2:45:00 PM	0.08
11/22/2025	3:00:00 PM	0.07
11/22/2025	3:15:00 PM	0.08
11/22/2025	3:30:00 PM	0.07
11/22/2025	3:45:00 PM	0.08
11/22/2025	4:00:00 PM	0.08
11/22/2025	4:15:00 PM	0.08
11/22/2025	4:30:00 PM	0.08
11/22/2025	4:45:00 PM	0.08
11/22/2025	5:00:00 PM	0.08
11/22/2025	5:15:00 PM	0.08
11/22/2025	5:30:00 PM	0.09
11/22/2025	5:45:00 PM	0.08
11/22/2025	6:00:00 PM	0.08
11/22/2025	6:15:00 PM	0.08
11/22/2025	6:30:00 PM	0.08
11/22/2025	6:45:00 PM	0.08
11/22/2025	7:00:00 PM	0.08
11/22/2025	7:15:00 PM	0.08
11/22/2025	7:30:00 PM	0.08
11/22/2025	7:45:00 PM	0.08
11/22/2025	8:00:00 PM	0.08
11/22/2025	8:15:00 PM	0.08
11/22/2025	8:30:00 PM	0.08
11/22/2025	8:45:00 PM	0.08
11/22/2025	9:00:00 PM	0.08
11/22/2025	9:15:00 PM	0.08
11/22/2025	9:30:00 PM	0.08
11/22/2025	9:45:00 PM	0.08
11/22/2025	10:00:00 PM	0.08
11/22/2025	10:15:00 PM	0.08
11/22/2025	10:30:00 PM	0.08
11/22/2025	10:45:00 PM	0.08
11/22/2025	11:00:00 PM	0.08
11/22/2025	11:15:00 PM	0.08
11/22/2025	11:30:00 PM	0.08
11/22/2025	11:45:00 PM	0.08
11/23/2025	12:00:00 AM	0.08
11/23/2025	12:15:00 AM	0.08
11/23/2025	12:30:00 AM	0.08
11/23/2025	12:45:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/23/2025	1:00:00 AM	0.08
11/23/2025	1:15:00 AM	0.08
11/23/2025	1:30:00 AM	0.08
11/23/2025	1:45:00 AM	0.08
11/23/2025	2:00:00 AM	0.08
11/23/2025	2:15:00 AM	0.08
11/23/2025	2:30:00 AM	0.08
11/23/2025	2:45:00 AM	0.08
11/23/2025	3:00:00 AM	0.08
11/23/2025	3:15:00 AM	0.08
11/23/2025	3:30:00 AM	0.08
11/23/2025	3:45:00 AM	0.08
11/23/2025	4:00:00 AM	0.08
11/23/2025	4:15:00 AM	0.08
11/23/2025	4:30:00 AM	0.08
11/23/2025	4:45:00 AM	0.08
11/23/2025	5:00:00 AM	0.08
11/23/2025	5:15:00 AM	0.08
11/23/2025	5:30:00 AM	0.08
11/23/2025	5:45:00 AM	0.08
11/23/2025	6:00:00 AM	0.08
11/23/2025	6:15:00 AM	0.08
11/23/2025	6:30:00 AM	0.08
11/23/2025	6:45:00 AM	0.08
11/23/2025	7:00:00 AM	0.08
11/23/2025	7:15:00 AM	0.08
11/23/2025	7:30:00 AM	0.08
11/23/2025	7:45:00 AM	0.08
11/23/2025	8:00:00 AM	0.08
11/23/2025	8:15:00 AM	0.08
11/23/2025	8:30:00 AM	0.08
11/23/2025	8:45:00 AM	0.08
11/23/2025	9:00:00 AM	0.08
11/23/2025	9:15:00 AM	0.08
11/23/2025	9:30:00 AM	0.08
11/23/2025	9:45:00 AM	0.08
11/23/2025	10:00:00 AM	0.08
11/23/2025	10:15:00 AM	0.08
11/23/2025	10:30:00 AM	0.08
11/23/2025	10:45:00 AM	0.08
11/23/2025	11:00:00 AM	0.08
11/23/2025	11:15:00 AM	0.08
11/23/2025	11:30:00 AM	0.08
11/23/2025	11:45:00 AM	0.08
11/23/2025	12:00:00 PM	0.08
11/23/2025	12:15:00 PM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/23/2025	12:30:00 PM	0.08
11/23/2025	12:45:00 PM	0.08
11/23/2025	1:00:00 PM	0.08
11/23/2025	1:15:00 PM	0.08
11/23/2025	1:30:00 PM	0.08
11/23/2025	1:45:00 PM	0.08
11/23/2025	2:00:00 PM	0.08
11/23/2025	2:15:00 PM	0.08
11/23/2025	2:30:00 PM	0.08
11/23/2025	2:45:00 PM	0.08
11/23/2025	3:00:00 PM	0.08
11/23/2025	3:15:00 PM	0.08
11/23/2025	3:30:00 PM	0.08
11/23/2025	3:45:00 PM	0.08
11/23/2025	4:00:00 PM	0.08
11/23/2025	4:15:00 PM	0.08
11/23/2025	4:30:00 PM	0.08
11/23/2025	4:45:00 PM	0.08
11/23/2025	5:00:00 PM	0.08
11/23/2025	5:15:00 PM	0.08
11/23/2025	5:30:00 PM	0.08
11/23/2025	5:45:00 PM	0.08
11/23/2025	6:00:00 PM	0.08
11/23/2025	6:15:00 PM	0.08
11/23/2025	6:30:00 PM	0.08
11/23/2025	6:45:00 PM	0.08
11/23/2025	7:00:00 PM	0.08
11/23/2025	7:15:00 PM	0.08
11/23/2025	7:30:00 PM	0.08
11/23/2025	7:45:00 PM	0.08
11/23/2025	8:00:00 PM	0.08
11/23/2025	8:15:00 PM	0.08
11/23/2025	8:30:00 PM	0.08
11/23/2025	8:45:00 PM	0.08
11/23/2025	9:00:00 PM	0.08
11/23/2025	9:15:00 PM	0.08
11/23/2025	9:30:00 PM	0.08
11/23/2025	9:45:00 PM	0.08
11/23/2025	10:00:00 PM	0.08
11/23/2025	10:15:00 PM	0.08
11/23/2025	10:30:00 PM	0.08
11/23/2025	10:45:00 PM	0.08
11/23/2025	11:00:00 PM	0.08
11/23/2025	11:15:00 PM	0.08
11/23/2025	11:30:00 PM	0.08
11/23/2025	11:45:00 PM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/24/2025	12:00:00 AM	0.08
11/24/2025	12:15:00 AM	0.08
11/24/2025	12:30:00 AM	0.08
11/24/2025	12:45:00 AM	0.08
11/24/2025	1:00:00 AM	0.08
11/24/2025	1:15:00 AM	0.08
11/24/2025	1:30:00 AM	0.08
11/24/2025	1:45:00 AM	0.08
11/24/2025	2:00:00 AM	0.08
11/24/2025	2:15:00 AM	0.08
11/24/2025	2:30:00 AM	0.08
11/24/2025	2:45:00 AM	0.08
11/24/2025	3:00:00 AM	0.08
11/24/2025	3:15:00 AM	0.08
11/24/2025	3:30:00 AM	0.08
11/24/2025	3:45:00 AM	0.08
11/24/2025	4:00:00 AM	0.08
11/24/2025	4:15:00 AM	0.08
11/24/2025	4:30:00 AM	0.08
11/24/2025	4:45:00 AM	0.08
11/24/2025	5:00:00 AM	0.08
11/24/2025	5:15:00 AM	0.08
11/24/2025	5:30:00 AM	0.08
11/24/2025	5:45:00 AM	0.08
11/24/2025	6:00:00 AM	0.08
11/24/2025	6:15:00 AM	0.08
11/24/2025	6:30:00 AM	0.08
11/24/2025	6:45:00 AM	0.08
11/24/2025	7:00:00 AM	0.08
11/24/2025	7:15:00 AM	0.08
11/24/2025	7:30:00 AM	0.08
11/24/2025	7:45:00 AM	0.08
11/24/2025	8:00:00 AM	0.08
11/24/2025	8:15:00 AM	0.07
11/24/2025	8:30:00 AM	0.07
11/24/2025	8:45:00 AM	0.07
11/24/2025	9:00:00 AM	0.07
11/24/2025	9:15:00 AM	0.07
11/24/2025	9:30:00 AM	0.07
11/24/2025	9:45:00 AM	0.07
11/24/2025	10:00:00 AM	0.07
11/24/2025	10:15:00 AM	0.07
11/24/2025	10:30:00 AM	0.07
11/24/2025	10:45:00 AM	0.07
11/24/2025	11:00:00 AM	0.07
11/24/2025	11:15:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
11/24/2025	11:30:00 AM	0.07
11/24/2025	11:45:00 AM	0.07
11/24/2025	12:00:00 PM	0.07
11/24/2025	12:15:00 PM	0.07
11/24/2025	12:30:00 PM	0.07
11/24/2025	12:45:00 PM	0.07
11/24/2025	1:00:00 PM	0.07
11/24/2025	1:15:00 PM	0.07
11/24/2025	1:30:00 PM	0.07
11/24/2025	1:45:00 PM	0.07
11/24/2025	2:00:00 PM	0.07
11/24/2025	2:15:00 PM	0.07
11/24/2025	2:30:00 PM	0.07
11/24/2025	2:45:00 PM	0.07
11/24/2025	3:00:00 PM	0.07
11/24/2025	3:15:00 PM	0.07
11/24/2025	3:30:00 PM	0.07
11/24/2025	3:45:00 PM	0.07
11/24/2025	4:00:00 PM	0.07
11/24/2025	4:15:00 PM	0.07
11/24/2025	4:30:00 PM	0.07
11/24/2025	4:45:00 PM	0.07
11/24/2025	5:00:00 PM	0.07
11/24/2025	5:15:00 PM	0.07
11/24/2025	5:30:00 PM	0.07
11/24/2025	5:45:00 PM	0.07
11/24/2025	6:00:00 PM	0.07
11/24/2025	6:15:00 PM	0.07
11/24/2025	6:30:00 PM	0.07
11/24/2025	6:45:00 PM	0.07
11/24/2025	7:00:00 PM	0.07
11/24/2025	7:15:00 PM	0.07
11/24/2025	7:30:00 PM	0.07
11/24/2025	7:45:00 PM	0.07
11/24/2025	8:00:00 PM	0.07
11/24/2025	8:15:00 PM	0.07
11/24/2025	8:30:00 PM	0.07
11/24/2025	8:45:00 PM	0.07
11/24/2025	9:00:00 PM	0.07
11/24/2025	9:15:00 PM	0.07
11/24/2025	9:30:00 PM	0.07
11/24/2025	9:45:00 PM	0.07
11/24/2025	10:00:00 PM	0.07
11/24/2025	10:15:00 PM	0.07
11/24/2025	10:30:00 PM	0.07
11/24/2025	10:45:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
11/24/2025	11:00:00 PM	0.07
11/24/2025	11:15:00 PM	0.07
11/24/2025	11:30:00 PM	0.07
11/24/2025	11:45:00 PM	0.07
11/25/2025	12:00:00 AM	0.07
11/25/2025	12:15:00 AM	0.07
11/25/2025	12:30:00 AM	0.07
11/25/2025	12:45:00 AM	0.07
11/25/2025	1:00:00 AM	0.07
11/25/2025	1:15:00 AM	0.07
11/25/2025	1:30:00 AM	0.07
11/25/2025	1:45:00 AM	0.07
11/25/2025	2:00:00 AM	0.07
11/25/2025	2:15:00 AM	0.07
11/25/2025	2:30:00 AM	0.07
11/25/2025	2:45:00 AM	0.07
11/25/2025	3:00:00 AM	0.07
11/25/2025	3:15:00 AM	0.07
11/25/2025	3:30:00 AM	0.07
11/25/2025	3:45:00 AM	0.07
11/25/2025	4:00:00 AM	0.07
11/25/2025	4:15:00 AM	0.07
11/25/2025	4:30:00 AM	0.07
11/25/2025	4:45:00 AM	0.07
11/25/2025	5:00:00 AM	0.07
11/25/2025	5:15:00 AM	0.07
11/25/2025	5:30:00 AM	0.07
11/25/2025	5:45:00 AM	0.07
11/25/2025	6:00:00 AM	0.07
11/25/2025	6:15:00 AM	0.07
11/25/2025	6:30:00 AM	0.07
11/25/2025	6:45:00 AM	0.07
11/25/2025	7:00:00 AM	0.07
11/25/2025	7:15:00 AM	0.07
11/25/2025	7:30:00 AM	0.07
11/25/2025	7:45:00 AM	0.07
11/25/2025	8:00:00 AM	0.07
11/25/2025	8:15:00 AM	0.07
11/25/2025	8:30:00 AM	0.07
11/25/2025	8:45:00 AM	0.07
11/25/2025	9:00:00 AM	0.07
11/25/2025	9:15:00 AM	0.07
11/25/2025	9:30:00 AM	0.07
11/25/2025	9:45:00 AM	0.07
11/25/2025	10:00:00 AM	0.07
11/25/2025	10:15:00 AM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
11/25/2025	10:30:00 AM	0.07
11/25/2025	10:45:00 AM	0.07
11/25/2025	11:00:00 AM	0.07
11/25/2025	11:15:00 AM	0.07
11/25/2025	11:30:00 AM	0.07
11/25/2025	11:45:00 AM	0.07
11/25/2025	12:00:00 PM	0.07
11/25/2025	12:15:00 PM	0.07
11/25/2025	12:30:00 PM	0.07
11/25/2025	12:45:00 PM	0.07
11/25/2025	1:00:00 PM	0.07
11/25/2025	1:15:00 PM	0.07
11/25/2025	1:30:00 PM	0.07
11/25/2025	1:45:00 PM	0.07
11/25/2025	2:00:00 PM	0.07
11/25/2025	2:15:00 PM	0.07
11/25/2025	2:30:00 PM	0.07
11/25/2025	2:45:00 PM	0.07
11/25/2025	3:00:00 PM	0.07
11/25/2025	3:15:00 PM	0.07
11/25/2025	3:30:00 PM	0.07
11/25/2025	3:45:00 PM	0.07
11/25/2025	4:00:00 PM	0.07
11/25/2025	4:15:00 PM	0.07
11/25/2025	4:30:00 PM	0.07
11/25/2025	4:45:00 PM	0.07
11/25/2025	5:00:00 PM	0.07
11/25/2025	5:15:00 PM	0.07
11/25/2025	5:30:00 PM	0.07
11/25/2025	5:45:00 PM	0.07
11/25/2025	6:00:00 PM	0.07
11/25/2025	6:15:00 PM	0.07
11/25/2025	6:30:00 PM	0.07
11/25/2025	6:45:00 PM	0.07
11/25/2025	7:00:00 PM	0.07
11/25/2025	7:15:00 PM	0.07
11/25/2025	7:30:00 PM	0.07
11/25/2025	7:45:00 PM	0.07
11/25/2025	8:00:00 PM	0.07
11/25/2025	8:15:00 PM	0.07
11/25/2025	8:30:00 PM	0.07
11/25/2025	8:45:00 PM	0.07
11/25/2025	9:00:00 PM	0.07
11/25/2025	9:15:00 PM	0.07
11/25/2025	9:30:00 PM	0.07
11/25/2025	9:45:00 PM	0.07

Georges Ditch Return Gage

DATE	TIME	GAGE
11/25/2025	10:00:00 PM	0.07
11/25/2025	10:15:00 PM	0.07
11/25/2025	10:30:00 PM	0.07
11/25/2025	10:45:00 PM	0.07
11/25/2025	11:00:00 PM	0.07
11/25/2025	11:15:00 PM	0.07
11/25/2025	11:30:00 PM	0.07
11/25/2025	11:45:00 PM	0.07
11/26/2025	12:00:00 AM	0.07
11/26/2025	12:15:00 AM	0.07
11/26/2025	12:30:00 AM	0.07
11/26/2025	12:45:00 AM	0.07
11/26/2025	1:00:00 AM	0.07
11/26/2025	1:15:00 AM	0.07
11/26/2025	1:30:00 AM	0.07
11/26/2025	1:45:00 AM	0.07
11/26/2025	2:00:00 AM	0.08
11/26/2025	2:15:00 AM	0.07
11/26/2025	2:30:00 AM	0.07
11/26/2025	2:45:00 AM	0.08
11/26/2025	3:00:00 AM	0.08
11/26/2025	3:15:00 AM	0.08
11/26/2025	3:30:00 AM	0.07
11/26/2025	3:45:00 AM	0.07
11/26/2025	4:00:00 AM	0.08
11/26/2025	4:15:00 AM	0.08
11/26/2025	4:30:00 AM	0.08
11/26/2025	4:45:00 AM	0.08
11/26/2025	5:00:00 AM	0.08
11/26/2025	5:15:00 AM	0.08
11/26/2025	5:30:00 AM	0.07
11/26/2025	5:45:00 AM	0.08
11/26/2025	6:00:00 AM	0.08
11/26/2025	6:15:00 AM	0.08
11/26/2025	6:30:00 AM	0.08
11/26/2025	6:45:00 AM	0.08
11/26/2025	7:00:00 AM	0.08
11/26/2025	7:15:00 AM	0.08
11/26/2025	7:30:00 AM	0.08
11/26/2025	7:45:00 AM	0.08
11/26/2025	8:00:00 AM	0.08
11/26/2025	8:15:00 AM	0.08
11/26/2025	8:30:00 AM	0.08
11/26/2025	8:45:00 AM	0.08
11/26/2025	9:00:00 AM	0.08
11/26/2025	9:15:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/26/2025	9:30:00 AM	0.08
11/26/2025	9:45:00 AM	0.08
11/26/2025	10:00:00 AM	0.08
11/26/2025	10:15:00 AM	0.08
11/26/2025	10:30:00 AM	0.08
11/26/2025	10:45:00 AM	0.08
11/26/2025	11:00:00 AM	0.08
11/26/2025	11:15:00 AM	0.08
11/26/2025	11:30:00 AM	0.08
11/26/2025	11:45:00 AM	0.08
11/26/2025	12:00:00 PM	0.08
11/26/2025	12:15:00 PM	0.08
11/26/2025	12:30:00 PM	0.08
11/26/2025	12:45:00 PM	0.08
11/26/2025	1:00:00 PM	0.08
11/26/2025	1:15:00 PM	0.08
11/26/2025	1:30:00 PM	0.08
11/26/2025	1:45:00 PM	0.08
11/26/2025	2:00:00 PM	0.08
11/26/2025	2:15:00 PM	0.08
11/26/2025	2:30:00 PM	0.08
11/26/2025	2:45:00 PM	0.08
11/26/2025	3:00:00 PM	0.08
11/26/2025	3:15:00 PM	0.08
11/26/2025	3:30:00 PM	0.08
11/26/2025	3:45:00 PM	0.08
11/26/2025	4:00:00 PM	0.08
11/26/2025	4:15:00 PM	0.08
11/26/2025	4:30:00 PM	0.08
11/26/2025	4:45:00 PM	0.08
11/26/2025	5:00:00 PM	0.08
11/26/2025	5:15:00 PM	0.08
11/26/2025	5:30:00 PM	0.08
11/26/2025	5:45:00 PM	0.08
11/26/2025	6:00:00 PM	0.08
11/26/2025	6:15:00 PM	0.08
11/26/2025	6:30:00 PM	0.08
11/26/2025	6:45:00 PM	0.08
11/26/2025	7:00:00 PM	0.08
11/26/2025	7:15:00 PM	0.08
11/26/2025	7:30:00 PM	0.08
11/26/2025	7:45:00 PM	0.08
11/26/2025	8:00:00 PM	0.08
11/26/2025	8:15:00 PM	0.08
11/26/2025	8:30:00 PM	0.08
11/26/2025	8:45:00 PM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/26/2025	9:00:00 PM	0.08
11/26/2025	9:15:00 PM	0.08
11/26/2025	9:30:00 PM	0.08
11/26/2025	9:45:00 PM	0.08
11/26/2025	10:00:00 PM	0.08
11/26/2025	10:15:00 PM	0.08
11/26/2025	10:30:00 PM	0.08
11/26/2025	10:45:00 PM	0.08
11/26/2025	11:00:00 PM	0.08
11/26/2025	11:15:00 PM	0.08
11/26/2025	11:30:00 PM	0.08
11/26/2025	11:45:00 PM	0.08
11/27/2025	12:00:00 AM	0.08
11/27/2025	12:15:00 AM	0.08
11/27/2025	12:30:00 AM	0.08
11/27/2025	12:45:00 AM	0.08
11/27/2025	1:00:00 AM	0.08
11/27/2025	1:15:00 AM	0.08
11/27/2025	1:30:00 AM	0.08
11/27/2025	1:45:00 AM	0.08
11/27/2025	2:00:00 AM	0.08
11/27/2025	2:15:00 AM	0.08
11/27/2025	2:30:00 AM	0.08
11/27/2025	2:45:00 AM	0.08
11/27/2025	3:00:00 AM	0.08
11/27/2025	3:15:00 AM	0.08
11/27/2025	3:30:00 AM	0.08
11/27/2025	3:45:00 AM	0.08
11/27/2025	4:00:00 AM	0.08
11/27/2025	4:15:00 AM	0.08
11/27/2025	4:30:00 AM	0.08
11/27/2025	4:45:00 AM	0.08
11/27/2025	5:00:00 AM	0.08
11/27/2025	5:15:00 AM	0.08
11/27/2025	5:30:00 AM	0.08
11/27/2025	5:45:00 AM	0.08
11/27/2025	6:00:00 AM	0.08
11/27/2025	6:15:00 AM	0.08
11/27/2025	6:30:00 AM	0.08
11/27/2025	6:45:00 AM	0.08
11/27/2025	7:00:00 AM	0.08
11/27/2025	7:15:00 AM	0.08
11/27/2025	7:30:00 AM	0.08
11/27/2025	7:45:00 AM	0.08
11/27/2025	8:00:00 AM	0.08
11/27/2025	8:15:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/27/2025	8:30:00 AM	0.08
11/27/2025	8:45:00 AM	0.08
11/27/2025	9:00:00 AM	0.08
11/27/2025	9:15:00 AM	0.08
11/27/2025	9:30:00 AM	0.08
11/27/2025	9:45:00 AM	0.08
11/27/2025	10:00:00 AM	0.08
11/27/2025	10:15:00 AM	0.08
11/27/2025	10:30:00 AM	0.08
11/27/2025	10:45:00 AM	0.08
11/27/2025	11:00:00 AM	0.08
11/27/2025	11:15:00 AM	0.08
11/27/2025	11:30:00 AM	0.08
11/27/2025	11:45:00 AM	0.08
11/27/2025	12:00:00 PM	0.08
11/27/2025	12:15:00 PM	0.08
11/27/2025	12:30:00 PM	0.08
11/27/2025	12:45:00 PM	0.08
11/27/2025	1:00:00 PM	0.08
11/27/2025	1:15:00 PM	0.08
11/27/2025	1:30:00 PM	0.08
11/27/2025	1:45:00 PM	0.08
11/27/2025	2:00:00 PM	0.08
11/27/2025	2:15:00 PM	0.08
11/27/2025	2:30:00 PM	0.08
11/27/2025	2:45:00 PM	0.08
11/27/2025	3:00:00 PM	0.08
11/27/2025	3:15:00 PM	0.08
11/27/2025	3:30:00 PM	0.08
11/27/2025	3:45:00 PM	0.08
11/27/2025	4:00:00 PM	0.08
11/27/2025	4:15:00 PM	0.08
11/27/2025	4:30:00 PM	0.08
11/27/2025	4:45:00 PM	0.08
11/27/2025	5:00:00 PM	0.08
11/27/2025	5:15:00 PM	0.08
11/27/2025	5:30:00 PM	0.08
11/27/2025	5:45:00 PM	0.08
11/27/2025	6:00:00 PM	0.08
11/27/2025	6:15:00 PM	0.08
11/27/2025	6:30:00 PM	0.08
11/27/2025	6:45:00 PM	0.08
11/27/2025	7:00:00 PM	0.08
11/27/2025	7:15:00 PM	0.08
11/27/2025	7:30:00 PM	0.08
11/27/2025	7:45:00 PM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/27/2025	8:00:00 PM	0.08
11/27/2025	8:15:00 PM	0.08
11/27/2025	8:30:00 PM	0.08
11/27/2025	8:45:00 PM	0.08
11/27/2025	9:00:00 PM	0.08
11/27/2025	9:15:00 PM	0.08
11/27/2025	9:30:00 PM	0.08
11/27/2025	9:45:00 PM	0.08
11/27/2025	10:00:00 PM	0.08
11/27/2025	10:15:00 PM	0.08
11/27/2025	10:30:00 PM	0.08
11/27/2025	10:45:00 PM	0.08
11/27/2025	11:00:00 PM	0.08
11/27/2025	11:15:00 PM	0.08
11/27/2025	11:30:00 PM	0.08
11/27/2025	11:45:00 PM	0.08
11/28/2025	12:00:00 AM	0.08
11/28/2025	12:15:00 AM	0.08
11/28/2025	12:30:00 AM	0.08
11/28/2025	12:45:00 AM	0.08
11/28/2025	1:00:00 AM	0.08
11/28/2025	1:15:00 AM	0.08
11/28/2025	1:30:00 AM	0.08
11/28/2025	1:45:00 AM	0.08
11/28/2025	2:00:00 AM	0.08
11/28/2025	2:15:00 AM	0.08
11/28/2025	2:30:00 AM	0.08
11/28/2025	2:45:00 AM	0.08
11/28/2025	3:00:00 AM	0.08
11/28/2025	3:15:00 AM	0.08
11/28/2025	3:30:00 AM	0.08
11/28/2025	3:45:00 AM	0.08
11/28/2025	4:00:00 AM	0.08
11/28/2025	4:15:00 AM	0.08
11/28/2025	4:30:00 AM	0.08
11/28/2025	4:45:00 AM	0.08
11/28/2025	5:00:00 AM	0.08
11/28/2025	5:15:00 AM	0.08
11/28/2025	5:30:00 AM	0.08
11/28/2025	5:45:00 AM	0.08
11/28/2025	6:00:00 AM	0.08
11/28/2025	6:15:00 AM	0.08
11/28/2025	6:30:00 AM	0.08
11/28/2025	6:45:00 AM	0.08
11/28/2025	7:00:00 AM	0.08
11/28/2025	7:15:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/28/2025	7:30:00 AM	0.08
11/28/2025	7:45:00 AM	0.08
11/28/2025	8:00:00 AM	0.08
11/28/2025	8:15:00 AM	0.09
11/28/2025	8:30:00 AM	0.09
11/28/2025	8:45:00 AM	0.09
11/28/2025	9:00:00 AM	0.09
11/28/2025	9:15:00 AM	0.09
11/28/2025	9:30:00 AM	0.09
11/28/2025	9:45:00 AM	0.09
11/28/2025	10:00:00 AM	0.09
11/28/2025	10:15:00 AM	0.09
11/28/2025	10:30:00 AM	0.09
11/28/2025	10:45:00 AM	0.09
11/28/2025	11:00:00 AM	0.09
11/28/2025	11:15:00 AM	0.09
11/28/2025	11:30:00 AM	0.09
11/28/2025	11:45:00 AM	0.09
11/28/2025	12:00:00 PM	0.09
11/28/2025	12:15:00 PM	0.09
11/28/2025	12:30:00 PM	0.09
11/28/2025	12:45:00 PM	0.09
11/28/2025	1:00:00 PM	0.09
11/28/2025	1:15:00 PM	0.09
11/28/2025	1:30:00 PM	0.09
11/28/2025	1:45:00 PM	0.09
11/28/2025	2:00:00 PM	0.09
11/28/2025	2:15:00 PM	0.09
11/28/2025	2:30:00 PM	0.09
11/28/2025	2:45:00 PM	0.09
11/28/2025	3:00:00 PM	0.09
11/28/2025	3:15:00 PM	0.09
11/28/2025	3:30:00 PM	0.09
11/28/2025	3:45:00 PM	0.09
11/28/2025	4:00:00 PM	0.09
11/28/2025	4:15:00 PM	0.09
11/28/2025	4:30:00 PM	0.09
11/28/2025	4:45:00 PM	0.09
11/28/2025	5:00:00 PM	0.09
11/28/2025	5:15:00 PM	0.09
11/28/2025	5:30:00 PM	0.09
11/28/2025	5:45:00 PM	0.09
11/28/2025	6:00:00 PM	0.09
11/28/2025	6:15:00 PM	0.09
11/28/2025	6:30:00 PM	0.09
11/28/2025	6:45:00 PM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
11/28/2025	7:00:00 PM	0.09
11/28/2025	7:15:00 PM	0.09
11/28/2025	7:30:00 PM	0.09
11/28/2025	7:45:00 PM	0.09
11/28/2025	8:00:00 PM	0.09
11/28/2025	8:15:00 PM	0.09
11/28/2025	8:30:00 PM	0.09
11/28/2025	8:45:00 PM	0.09
11/28/2025	9:00:00 PM	0.09
11/28/2025	9:15:00 PM	0.09
11/28/2025	9:30:00 PM	0.09
11/28/2025	9:45:00 PM	0.09
11/28/2025	10:00:00 PM	0.09
11/28/2025	10:15:00 PM	0.09
11/28/2025	10:30:00 PM	0.09
11/28/2025	10:45:00 PM	0.09
11/28/2025	11:00:00 PM	0.09
11/28/2025	11:15:00 PM	0.09
11/28/2025	11:30:00 PM	0.09
11/28/2025	11:45:00 PM	0.09
11/29/2025	12:00:00 AM	0.09
11/29/2025	12:15:00 AM	0.09
11/29/2025	12:30:00 AM	0.09
11/29/2025	12:45:00 AM	0.09
11/29/2025	1:00:00 AM	0.09
11/29/2025	1:15:00 AM	0.09
11/29/2025	1:30:00 AM	0.09
11/29/2025	1:45:00 AM	0.09
11/29/2025	2:00:00 AM	0.09
11/29/2025	2:15:00 AM	0.09
11/29/2025	2:30:00 AM	0.09
11/29/2025	2:45:00 AM	0.09
11/29/2025	3:00:00 AM	0.09
11/29/2025	3:15:00 AM	0.09
11/29/2025	3:30:00 AM	0.09
11/29/2025	3:45:00 AM	0.09
11/29/2025	4:00:00 AM	0.09
11/29/2025	4:15:00 AM	0.09
11/29/2025	4:30:00 AM	0.09
11/29/2025	4:45:00 AM	0.09
11/29/2025	5:00:00 AM	0.09
11/29/2025	5:15:00 AM	0.09
11/29/2025	5:30:00 AM	0.09
11/29/2025	5:45:00 AM	0.09
11/29/2025	6:00:00 AM	0.09
11/29/2025	6:15:00 AM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
11/29/2025	6:30:00 AM	0.09
11/29/2025	6:45:00 AM	0.09
11/29/2025	7:00:00 AM	0.09
11/29/2025	7:15:00 AM	0.09
11/29/2025	7:30:00 AM	0.09
11/29/2025	7:45:00 AM	0.09
11/29/2025	8:00:00 AM	0.09
11/29/2025	8:15:00 AM	0.09
11/29/2025	8:30:00 AM	0.09
11/29/2025	8:45:00 AM	0.09
11/29/2025	9:00:00 AM	0.09
11/29/2025	9:15:00 AM	0.09
11/29/2025	9:30:00 AM	0.09
11/29/2025	9:45:00 AM	0.09
11/29/2025	10:00:00 AM	0.09
11/29/2025	10:15:00 AM	0.09
11/29/2025	10:30:00 AM	0.09
11/29/2025	10:45:00 AM	0.09
11/29/2025	11:00:00 AM	0.09
11/29/2025	11:15:00 AM	0.09
11/29/2025	11:30:00 AM	0.09
11/29/2025	11:45:00 AM	0.09
11/29/2025	12:00:00 PM	0.09
11/29/2025	12:15:00 PM	0.09
11/29/2025	12:30:00 PM	0.09
11/29/2025	12:45:00 PM	0.09
11/29/2025	1:00:00 PM	0.09
11/29/2025	1:15:00 PM	0.09
11/29/2025	1:30:00 PM	0.09
11/29/2025	1:45:00 PM	0.09
11/29/2025	2:00:00 PM	0.09
11/29/2025	2:15:00 PM	0.09
11/29/2025	2:30:00 PM	0.09
11/29/2025	2:45:00 PM	0.09
11/29/2025	3:00:00 PM	0.09
11/29/2025	3:15:00 PM	0.09
11/29/2025	3:30:00 PM	0.09
11/29/2025	3:45:00 PM	0.09
11/29/2025	4:00:00 PM	0.09
11/29/2025	4:15:00 PM	0.09
11/29/2025	4:30:00 PM	0.09
11/29/2025	4:45:00 PM	0.09
11/29/2025	5:00:00 PM	0.09
11/29/2025	5:15:00 PM	0.09
11/29/2025	5:30:00 PM	0.09
11/29/2025	5:45:00 PM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
11/29/2025	6:00:00 PM	0.09
11/29/2025	6:15:00 PM	0.09
11/29/2025	6:30:00 PM	0.09
11/29/2025	6:45:00 PM	0.09
11/29/2025	7:00:00 PM	0.09
11/29/2025	7:15:00 PM	0.09
11/29/2025	7:30:00 PM	0.09
11/29/2025	7:45:00 PM	0.09
11/29/2025	8:00:00 PM	0.09
11/29/2025	8:15:00 PM	0.09
11/29/2025	8:30:00 PM	0.09
11/29/2025	8:45:00 PM	0.09
11/29/2025	9:00:00 PM	0.09
11/29/2025	9:15:00 PM	0.09
11/29/2025	9:30:00 PM	0.09
11/29/2025	9:45:00 PM	0.09
11/29/2025	10:00:00 PM	0.09
11/29/2025	10:15:00 PM	0.09
11/29/2025	10:30:00 PM	0.09
11/29/2025	10:45:00 PM	0.09
11/29/2025	11:00:00 PM	0.09
11/29/2025	11:15:00 PM	0.09
11/29/2025	11:30:00 PM	0.09
11/29/2025	11:45:00 PM	0.09
11/30/2025	12:00:00 AM	0.09
11/30/2025	12:15:00 AM	0.09
11/30/2025	12:30:00 AM	0.09
11/30/2025	12:45:00 AM	0.09
11/30/2025	1:00:00 AM	0.09
11/30/2025	1:15:00 AM	0.09
11/30/2025	1:30:00 AM	0.09
11/30/2025	1:45:00 AM	0.09
11/30/2025	2:00:00 AM	0.09
11/30/2025	2:15:00 AM	0.09
11/30/2025	2:30:00 AM	0.09
11/30/2025	2:45:00 AM	0.09
11/30/2025	3:00:00 AM	0.09
11/30/2025	3:15:00 AM	0.09
11/30/2025	3:30:00 AM	0.09
11/30/2025	3:45:00 AM	0.09
11/30/2025	4:00:00 AM	0.09
11/30/2025	4:15:00 AM	0.09
11/30/2025	4:30:00 AM	0.09
11/30/2025	4:45:00 AM	0.09
11/30/2025	5:00:00 AM	0.09
11/30/2025	5:15:00 AM	0.09

Georges Ditch Return Gage

DATE	TIME	GAGE
11/30/2025	5:30:00 AM	0.09
11/30/2025	5:45:00 AM	0.09
11/30/2025	6:00:00 AM	0.09
11/30/2025	6:15:00 AM	0.09
11/30/2025	6:30:00 AM	0.09
11/30/2025	6:45:00 AM	0.09
11/30/2025	7:00:00 AM	0.09
11/30/2025	7:15:00 AM	0.09
11/30/2025	7:30:00 AM	0.09
11/30/2025	7:45:00 AM	0.09
11/30/2025	8:00:00 AM	0.09
11/30/2025	8:15:00 AM	0.09
11/30/2025	8:30:00 AM	0.09
11/30/2025	8:45:00 AM	0.09
11/30/2025	9:00:00 AM	0.09
11/30/2025	9:15:00 AM	0.09
11/30/2025	9:30:00 AM	0.09
11/30/2025	9:45:00 AM	0.09
11/30/2025	10:00:00 AM	0.09
11/30/2025	10:15:00 AM	0.09
11/30/2025	10:30:00 AM	0.09
11/30/2025	10:45:00 AM	0.09
11/30/2025	11:00:00 AM	0.09
11/30/2025	11:15:00 AM	0.09
11/30/2025	11:30:00 AM	0.09
11/30/2025	11:45:00 AM	0.09
11/30/2025	12:00:00 PM	0.09
11/30/2025	12:15:00 PM	0.09
11/30/2025	12:30:00 PM	0.09
11/30/2025	12:45:00 PM	0.09
11/30/2025	1:00:00 PM	0.08
11/30/2025	1:15:00 PM	0.08
11/30/2025	1:30:00 PM	0.08
11/30/2025	1:45:00 PM	0.08
11/30/2025	2:00:00 PM	0.08
11/30/2025	2:15:00 PM	0.08
11/30/2025	2:30:00 PM	0.08
11/30/2025	2:45:00 PM	0.08
11/30/2025	3:00:00 PM	0.08
11/30/2025	3:15:00 PM	0.08
11/30/2025	3:30:00 PM	0.08
11/30/2025	3:45:00 PM	0.08
11/30/2025	4:00:00 PM	0.08
11/30/2025	4:15:00 PM	0.08
11/30/2025	4:30:00 PM	0.08
11/30/2025	4:45:00 PM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
11/30/2025	5:00:00 PM	0.08
11/30/2025	5:15:00 PM	0.08
11/30/2025	5:30:00 PM	0.08
11/30/2025	5:45:00 PM	0.08
11/30/2025	6:00:00 PM	0.08
11/30/2025	6:15:00 PM	0.08
11/30/2025	6:30:00 PM	0.08
11/30/2025	6:45:00 PM	0.08
11/30/2025	7:00:00 PM	0.08
11/30/2025	7:15:00 PM	0.08
11/30/2025	7:30:00 PM	0.08
11/30/2025	7:45:00 PM	0.08
11/30/2025	8:00:00 PM	0.08
11/30/2025	8:15:00 PM	0.08
11/30/2025	8:30:00 PM	0.08
11/30/2025	8:45:00 PM	0.08
11/30/2025	9:00:00 PM	0.08
11/30/2025	9:15:00 PM	0.08
11/30/2025	9:30:00 PM	0.08
11/30/2025	9:45:00 PM	0.08
11/30/2025	10:00:00 PM	0.08
11/30/2025	10:15:00 PM	0.08
11/30/2025	10:30:00 PM	0.08
11/30/2025	10:45:00 PM	0.08
11/30/2025	11:00:00 PM	0.08
11/30/2025	11:15:00 PM	0.08
11/30/2025	11:30:00 PM	0.08
11/30/2025	11:45:00 PM	0.08

Party: CBR BRP	Width: 21.2 ft	Processed by: BJA
Boat/Motor: BOAT	Area: 80.1 ft ²	Mean Velocity: 0.685 ft/s
Gage Height: 3.66 ft	G.H.Change: 0.000 ft	Discharge: 54.8 ft ³ /s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.00°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft ²	Diff.: 0.000%
Depth: Composite (BT)	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:		ADCP:	
BT 3-Beam Solution: YES	Max. Vel.: 3.52 ft/s	Type/Freq.: StreamPro / 2000 kHz	
WT 3-Beam Solution: YES	Max. Depth: 3.81 ft	Serial #: 2370	Firmware: 31.17
BT Error Vel.: 0.33 ft/s	Mean Depth: 3.77 ft	Bin Size: 4 cm	Blank: 3 cm
WT Error Vel.: 1.41 ft/s	% Meas.: 63.19	BT Mode: 10	BT Pings: 2
BT Up Vel.: 1.00 ft/s	Water Temp.: None	WT Mode: 12	WT Pings: 6
WT Up Vel.: 1.64 ft/s	ADCP Temp.: 62.9 °F		
Use Weighted Mean Depth: YES			

Performed Diag. Test: NO
 Performed Moving Bed Test: NO
 Performed Compass Calibration: NO Evaluation: NO
 Meas. Location: BRIDGE

Project Name: 251125 RINKL_0.mmt
 Software: 2.26.00.04

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	L	2	2	48	6.25	34.1	4.20	4.10	4.63	53.3	21	80	11:15	11:16	0.33	0.67	0	1
001	R	2	2	52	6.43	34.5	4.87	5.09	3.81	54.7	21	80	11:16	11:17	0.31	0.69	0	1
002	L	2	2	50	6.57	34.9	4.80	5.90	4.41	56.5	21	80	11:17	11:18	0.31	0.71	0	1
003	R	2	2	54	6.57	35.0	5.05	4.59	3.43	54.7	21	81	11:18	11:19	0.30	0.68	0	1
Mean		2	2	51	6.45	34.6	4.73	4.92	4.07	54.8	21	80	Total	00:04	0.31	0.68	0	1
SDev		0	0	3	0.151	0.417	0.368	0.768	0.550	1.32	0.1	0.3			0.02	0.02		
SD/M		0.0%	0.0%	5.1%	2.3%	1.2%	7.8%	15.6%	13.5%	2.4%	0.6%	0.4%			4.9%	2.6%		

Remarks:

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	1	0	2	15	24.7	-2.8	1.032	0.5	0.4	0	41.7	31.4	0	132	107	0	35	34	34
2025	11	1	0	12	15	24.9	-3	1.032	0.5	0.4	0	42.1	31.4	0	133	107	0	35	34	34
2025	11	1	0	22	15	24.7	-2.9	1.031	0.3	0.2	0	42.1	31.8	0	133	107	0	35	33	35
2025	11	1	0	32	15	25	-2.8	1.031	0.5	0.5	0	42.1	31.4	0	133	107	0	35	34	35
2025	11	1	0	42	15	24.8	-3.4	1.031	0.4	0.3	0	42.1	31.8	0	133	107	0	35	33	35
2025	11	1	0	52	15	25.6	-3.1	1.031	0.5	0.4	0	42.1	31.4	0	133	107	0	35	34	35
2025	11	1	1	2	15	25.9	-2.7	1.032	0.5	0.5	0	41.7	31.8	0	132	107	0	35	33	35
2025	11	1	1	12	15	25.3	-3.8	1.031	0.5	0.4	0	42.1	31.4	0	133	107	0	35	34	34
2025	11	1	1	22	15	25.5	-2.5	1.031	0.4	0.3	0	42.1	31.4	0	133	107	0	35	34	35
2025	11	1	1	32	15	24.7	-2.8	1.031	0.5	0.4	0	41.7	31	0	132	106	0	35	34	34
2025	11	1	1	42	15	25.8	-2.9	1.031	0.4	0.3	0	42.6	31.4	0	133	107	0	34	34	34
2025	11	1	1	52	15	24.6	-1.7	1.031	0.4	0.3	0	42.1	31.4	0	133	107	0	35	34	34
2025	11	1	2	2	15	25.5	-3.3	1.031	0.5	0.4	0	42.1	31.4	0	133	107	0	35	34	34
2025	11	1	2	12	15	25.1	-2.6	1.031	0.5	0.4	0	42.1	31.8	0	133	107	0	35	33	34
2025	11	1	2	22	15	24.2	-2.4	1.031	0.5	0.5	0	42.1	31.8	0	133	107	0	35	33	34
2025	11	1	2	32	15	25	-3.6	1.031	0.4	0.3	0	41.7	31.4	0	132	106	0	35	33	35
2025	11	1	2	42	15	25.1	-3.6	1.031	0.5	0.4	0	42.1	31.4	0	132	106	0	34	33	34
2025	11	1	2	52	15	25.6	-2.8	1.031	0.5	0.4	0	41.7	31	0	132	106	0	35	34	35
2025	11	1	3	2	15	24.5	-3.3	1.031	0.3	0.2	0	42.1	31	0	132	106	0	34	34	34
2025	11	1	3	12	15	25.2	-3.3	1.031	0.4	0.3	0	42.1	31.4	0	133	107	0	35	34	34
2025	11	1	3	22	15	25.6	-2.8	1.031	0.4	0.3	0	41.7	31.4	0	132	107	0	35	34	35
2025	11	1	3	32	15	25	-3.8	1.031	0.4	0.3	0	42.1	31.4	0	133	107	0	35	34	35
2025	11	1	3	42	15	24.4	-3.2	1.031	0.5	0.4	0	41.7	31.4	0	133	107	0	36	34	34
2025	11	1	3	52	15	25.6	-3.1	1.031	0.3	0.2	0	41.7	31.4	0	131	107	0	34	34	35
2025	11	1	4	2	15	25.8	-2.5	1.031	0.4	0.3	0	42.1	31	0	133	106	0	35	34	34
2025	11	1	4	12	15	24.1	-3	1.031	0.5	0.4	0	42.6	31.8	0	134	107	0	35	33	35
2025	11	1	4	22	15	25.2	-3	1.031	0.5	0.4	0	42.1	31	0	133	106	0	35	34	35
2025	11	1	4	32	15	25.5	-3.8	1.031	0.5	0.4	0	42.1	31	0	133	106	0	35	34	35
2025	11	1	4	42	15	25.2	-3.2	1.031	0.3	0.2	0	42.1	31	0	133	106	0	35	34	34
2025	11	1	4	52	15	24.6	-3.2	1.031	0.5	0.4	0	42.6	31	0	134	106	0	35	34	35
2025	11	1	5	2	15	24.7	-2.2	1.031	0.4	0.3	0	42.1	31.4	0	133	107	0	35	34	34
2025	11	1	5	12	15	25.2	-2.5	1.031	0.5	0.4	0	42.1	31.4	0	133	106	0	35	33	34
2025	11	1	5	22	15	25.1	-2.3	1.031	0.4	0.3	0	42.6	31.4	0	134	107	0	35	34	35
2025	11	1	5	32	15	25.8	-2.6	1.031	0.3	0.2	0	42.1	31.4	0	133	106	0	35	33	34
2025	11	1	5	42	15	23.6	-2.9	1.031	0.5	0.5	0	42.6	31.4	0	133	106	0	34	33	35
2025	11	1	5	52	15	25.2	-2.9	1.031	0.3	0.2	0	42.6	31	0	133	106	0	34	34	34
2025	11	1	6	2	15	25	-1.5	1.031	0.4	0.3	0	42.1	30.5	0	133	105	0	35	34	35
2025	11	1	6	12	15	24	-3.5	1.032	0.4	0.3	0	42.1	31	0	133	106	0	35	34	34
2025	11	1	6	22	15	24.7	-3	1.032	0.5	0.4	0	41.7	30.5	0	132	105	0	35	34	34
2025	11	1	6	32	15	25.3	-3.3	1.031	0.4	0.3	0	41.7	30.5	0	132	105	0	35	34	34
2025	11	1	6	42	15	25.9	-2.9	1.031	0.5	0.4	0	41.7	31	0	132	105	0	35	33	34
2025	11	1	6	52	15	25.8	-3.1	1.032	0.4	0.3	0	41.3	30.5	0	131	105	0	35	34	34
2025	11	1	7	2	15	24.6	-4.3	1.032	0.4	0.3	0	41.3	30.1	0	131	104	0	35	34	35
2025	11	1	7	12	15	25.1	-2.8	1.032	0.4	0.3	0	41.3	30.1	0	131	104	0	35	34	35
2025	11	1	7	22	15	24.3	-2.5	1.032	0.4	0.3	0	41.3	30.1	0	131	104	0	35	34	34
2025	11	1	7	32	15	25.6	-2.6	1.032	0.4	0.3	0	41.3	30.1	0	131	104	0	35	34	35
2025	11	1	7	42	15	24.1	-3.2	1.032	0.3	0.2	0	40.9	29.7	0	130	103	0	35	34	34
2025	11	1	7	52	15	24.2	-2.1	1.032	0.5	0.5	0	40.9	30.1	0	130	103	0	35	33	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	1	8	2	15	24.5	-3.4	1.033	0.4	0.3	0	40.9	30.1	0	130	103	0	35	33	35
2025	11	1	8	12	15	25.6	-2.3	1.033	0.5	0.5	0	41.3	29.7	0	130	103	0	34	34	34
2025	11	1	8	22	15	25.4	-3.2	1.033	0.3	0.2	0	40.4	29.7	0	129	102	0	35	33	35
2025	11	1	8	32	15	25.1	-2.6	1.033	0.5	0.4	0	40.4	29.7	0	129	103	0	35	34	35
2025	11	1	8	42	15	25.2	-2.7	1.033	0.4	0.3	0	40.4	29.2	0	129	102	0	35	34	34
2025	11	1	8	52	15	24.6	-3.8	1.033	0.5	0.4	0	40.4	29.2	0	129	102	0	35	34	34
2025	11	1	9	2	15	26	-3.3	1.032	0.4	0.3	0	39.6	28.8	0	127	101	0	35	34	34
2025	11	1	9	12	15	24.9	-3.2	1.033	0.5	0.4	0	39.6	28.4	0	126	100	0	34	34	34
2025	11	1	9	22	15	23.9	-1.2	1.033	0.5	0.4	0	39.6	28.8	0	127	100	0	35	33	34
2025	11	1	9	32	15	25	-3.9	1.033	0.3	0.2	0	39.1	28	0	126	99	0	35	34	34
2025	11	1	9	42	15	25.6	-3.2	1.034	0.4	0.3	0	39.1	28	0	126	99	0	35	34	34
2025	11	1	9	52	15	23.9	-3.6	1.033	0.5	0.4	0	39.6	28.4	0	127	99	0	35	33	34
2025	11	1	10	2	15	25.3	-2.8	1.033	0.4	0.3	0	39.1	28	0	126	99	0	35	34	34
2025	11	1	10	12	15	25.3	-2.9	1.034	0.4	0.3	0	39.6	28.8	0	127	100	0	35	33	35
2025	11	1	10	22	15	25.8	-3.3	1.033	0.4	0.3	0	39.6	28.8	0	127	101	0	35	34	34
2025	11	1	10	32	15	25.3	-3	1.033	0.4	0.3	0	39.6	28.8	0	127	101	0	35	34	35
2025	11	1	10	42	15	25.2	-2.6	1.033	0.4	0.3	0	39.1	28.8	0	126	100	0	35	33	34
2025	11	1	10	52	15	25.4	-3.5	1.033	0.3	0.2	0	40	28.4	0	127	100	0	34	34	34
2025	11	1	11	2	15	24	-3.4	1.033	0.4	0.3	0	39.6	28.4	0	127	100	0	35	34	35
2025	11	1	11	12	15	24.8	-3.2	1.033	0.5	0.4	0	39.1	28.4	0	126	100	0	35	34	35
2025	11	1	11	22	15	24	-3	1.033	0.4	0.3	0	40	29.2	0	128	101	0	35	33	34
2025	11	1	11	32	15	24.1	-3.7	1.034	0.3	0.2	0	40	28.8	0	128	101	0	35	34	34
2025	11	1	11	42	15	26	-3	1.034	0.5	0.4	0	39.6	28.4	0	127	100	0	35	34	34
2025	11	1	11	52	15	25.4	-3	1.034	0.5	0.4	0	39.1	28.8	0	126	100	0	35	33	35
2025	11	1	12	2	15	25.4	-3.2	1.034	0.5	0.4	0	39.1	28	0	126	99	0	35	34	34
2025	11	1	12	12	15	24.8	-2.6	1.034	0.3	0.2	0	39.6	28.8	0	127	101	0	35	34	34
2025	11	1	12	22	15	25.8	-2.9	1.034	0.4	0.3	0	39.1	28.4	0	126	100	0	35	34	35
2025	11	1	12	32	15	25.2	-3.3	1.034	0.4	0.3	0	39.6	28.8	0	127	101	0	35	34	34
2025	11	1	12	42	15	25.1	-3.5	1.034	0.5	0.4	0	40.4	28.8	0	128	101	0	34	34	34
2025	11	1	12	52	15	24.7	-2	1.034	0.4	0.3	0	40.9	29.2	0	129	102	0	34	34	35
2025	11	1	13	2	15	25	-3.6	1.034	0.4	0.3	0	40.4	29.7	0	128	102	0	34	33	35
2025	11	1	13	12	15	25.9	-3.7	1.034	0.5	0.4	0	39.1	28.4	0	126	100	0	35	34	35
2025	11	1	13	22	15	24.5	-3.6	1.034	0.3	0.2	0	40	28.8	0	127	101	0	34	34	34
2025	11	1	13	32	15	24	-3.2	1.034	0.4	0.3	0	39.6	29.2	0	127	101	0	35	33	35
2025	11	1	13	42	15	24.6	-3.5	1.034	0.5	0.4	0	39.6	28.8	0	126	100	0	34	33	34
2025	11	1	13	52	15	26.4	-3.5	1.034	0.3	0.2	0	39.1	28	0	126	99	0	35	34	34
2025	11	1	14	2	15	24.9	-2.8	1.034	0.4	0.3	0	39.6	28.8	0	127	100	0	35	33	35
2025	11	1	14	12	15	24.8	-2.4	1.034	0.4	0.3	0	39.1	28	0	126	99	0	35	34	34
2025	11	1	14	22	15	23.6	-3.1	1.034	0.3	0.2	0	39.6	28.8	0	127	101	0	35	34	34
2025	11	1	14	32	15	25.9	-3.1	1.034	0.4	0.3	0	39.1	28.4	0	126	100	0	35	34	34
2025	11	1	14	42	15	23.7	-2.5	1.034	0.5	0.4	0	39.6	29.2	0	127	101	0	35	33	34
2025	11	1	14	52	15	24.5	-3.3	1.033	0.4	0.3	0	40	29.2	0	127	101	0	34	33	35
2025	11	1	15	2	15	24.1	-2	1.033	0.4	0.3	0	39.6	28.8	0	127	101	0	35	34	35
2025	11	1	15	12	15	23.5	-2.6	1.033	0.3	0.2	0	40	29.7	0	128	102	0	35	33	34
2025	11	1	15	22	15	24.2	-2.7	1.033	0.3	0.2	0	40	29.7	0	128	102	0	35	33	34
2025	11	1	15	32	15	25	-1.9	1.033	0.6	0.5	0	39.6	29.2	0	127	101	0	35	33	35
2025	11	1	15	42	15	24.2	-3.3	1.033	0.5	0.4	0	39.6	28.8	0	127	101	0	35	34	34
2025	11	1	15	52	15	24.7	-3	1.034	0.5	0.4	0	39.1	28.8	0	126	100	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	1	16	2	15	24.5	-3.6	1.033	0.3	0.2	0	39.6	29.2	0	127	102	0	35	34	34
2025	11	1	16	12	15	25.3	-3	1.033	0.4	0.3	0	40.9	29.7	0	129	103	0	34	34	34
2025	11	1	16	22	15	25.5	-2.6	1.033	0.5	0.4	0	40	29.2	0	128	101	0	35	33	35
2025	11	1	16	32	15	24.8	-3.4	1.033	0.4	0.3	0	39.1	28.4	0	126	100	0	35	34	35
2025	11	1	16	42	15	24.4	-3.7	1.033	0.3	0.2	0	39.6	28.8	0	126	100	0	34	33	33
2025	11	1	16	52	15	26.1	-3.2	1.033	0.4	0.3	0	39.6	28.4	0	126	99	0	34	33	34
2025	11	1	17	2	15	25.1	-2.9	1.033	0.3	0.2	0	40	28.8	0	127	100	0	34	33	35
2025	11	1	17	12	15	25.6	-3.5	1.033	0.5	0.4	0	40	28	0	127	99	0	34	34	35
2025	11	1	17	22	15	25.7	-3	1.033	0.4	0.3	0	39.6	28.8	0	127	100	0	35	33	34
2025	11	1	17	32	15	25.4	-2.3	1.033	0.4	0.3	0	39.6	28.4	0	127	100	0	35	34	34
2025	11	1	17	42	15	24.7	-2.5	1.033	0.5	0.4	0	40.4	28.8	0	128	101	0	34	34	35
2025	11	1	17	52	15	24.6	-1.9	1.033	0.4	0.3	0	40.9	30.1	0	130	103	0	35	33	34
2025	11	1	18	2	15	23.8	-2.6	1.033	0.3	0.2	0	40.9	30.5	0	130	104	0	35	33	35
2025	11	1	18	12	15	25.8	-3	1.033	0.4	0.3	0	42.1	30.5	0	132	104	0	34	33	34
2025	11	1	18	22	15	25.5	-3.1	1.033	0.4	0.3	0	41.7	30.5	0	131	104	0	34	33	34
2025	11	1	18	32	15	26.7	-3.5	1.033	0.4	0.3	0	41.7	30.1	0	131	104	0	34	34	34
2025	11	1	18	42	15	24	-2.6	1.033	0.5	0.4	0	41.7	31	0	132	105	0	35	33	34
2025	11	1	18	52	15	25.5	-4.2	1.033	0.5	0.4	0	42.1	30.5	0	133	105	0	35	34	35
2025	11	1	19	2	15	25.6	-3.5	1.033	0.3	0.2	0	42.6	31	0	133	106	0	34	34	35
2025	11	1	19	12	15	24.6	-2.7	1.033	0.4	0.3	0	41.7	31	0	132	105	0	35	33	34
2025	11	1	19	22	15	25.5	-3	1.033	0.5	0.4	0	42.6	31	0	133	106	0	34	34	34
2025	11	1	19	32	15	26	-3.6	1.033	0.4	0.3	0	41.7	31	0	132	106	0	35	34	35
2025	11	1	19	42	15	26.3	-3.3	1.034	0.5	0.4	0	42.1	31.4	0	133	106	0	35	33	35
2025	11	1	19	52	15	25.3	-3	1.034	0.4	0.3	0	42.6	31	0	133	106	0	34	34	35
2025	11	1	20	2	15	26	-4.1	1.034	0.3	0.2	0	41.7	31	0	132	105	0	35	33	35
2025	11	1	20	12	15	25.2	-3.3	1.034	0.3	0.2	0	42.1	31	0	133	106	0	35	34	35
2025	11	1	20	22	15	24.7	-3.6	1.034	0.5	0.4	0	42.1	31	0	133	106	0	35	34	35
2025	11	1	20	32	15	25.7	-3.2	1.034	0.4	0.3	0	42.1	31	0	133	106	0	35	34	34
2025	11	1	20	42	15	24.8	-3	1.034	0.3	0.2	0	42.1	31	0	133	106	0	35	34	34
2025	11	1	20	52	15	25.8	-3.6	1.034	0.3	0.2	0	42.1	31	0	132	106	0	34	34	34
2025	11	1	21	2	15	24.9	-2.5	1.034	0.4	0.3	0	42.6	31.4	0	134	107	0	35	34	34
2025	11	1	21	12	15	25.8	-3.1	1.035	0.4	0.3	0	42.6	31	0	133	106	0	34	34	34
2025	11	1	21	22	15	24.2	-1.8	1.035	0.4	0.3	0	42.1	31	0	133	106	0	35	34	35
2025	11	1	21	32	15	25.2	-3.8	1.035	0.5	0.4	0	41.7	31	0	132	106	0	35	34	34
2025	11	1	21	42	15	24.7	-2.6	1.035	0.5	0.4	0	42.6	31.4	0	133	106	0	34	33	34
2025	11	1	21	52	15	25.1	-4.2	1.035	0.3	0.2	0	42.1	31	0	133	106	0	35	34	34
2025	11	1	22	2	15	25.5	-3.5	1.035	0.5	0.4	0	41.7	31	0	132	106	0	35	34	34
2025	11	1	22	12	15	25.9	-3.7	1.035	0.5	0.4	0	41.7	31	0	132	106	0	35	34	34
2025	11	1	22	22	15	26.1	-2.9	1.034	0.4	0.3	0	41.7	31	0	132	106	0	35	34	34
2025	11	1	22	32	15	26.8	-3.4	1.035	0.3	0.2	0	42.1	31	0	133	106	0	35	34	34
2025	11	1	22	42	15	25.1	-2.2	1.035	0.5	0.5	0	42.6	31.4	0	134	107	0	35	34	34
2025	11	1	22	52	15	25.2	-3.7	1.035	0.4	0.3	0	41.7	31	0	132	106	0	35	34	34
2025	11	1	23	2	15	24.5	-3.1	1.035	0.3	0.2	0	42.1	31.4	0	133	107	0	35	34	34
2025	11	1	23	12	15	25.9	-2.9	1.035	0.5	0.4	0	41.7	31.4	0	132	106	0	35	33	34
2025	11	1	23	22	15	24.7	-3.3	1.035	0.4	0.3	0	42.1	31.8	0	133	107	0	35	33	35
2025	11	1	23	32	15	26.2	-2.5	1.035	0.4	0.3	0	42.1	31	0	132	106	0	34	34	35
2025	11	1	23	42	15	25.1	-2.6	1.035	0.4	0.3	0	42.1	31.4	0	133	107	0	35	34	35
2025	11	1	23	52	15	26.1	-3.4	1.035	0.5	0.5	0	41.7	31	0	132	106	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	2	0	2	15	24.6	-3.1	1.035	0.5	0.4	0	42.1	31	0	133	106	0	35	34	35
2025	11	2	0	12	15	24.2	-2.9	1.035	0.3	0.2	0	41.7	31	0	132	106	0	35	34	34
2025	11	2	0	22	15	25.8	-2.9	1.035	0.3	0.2	0	42.1	31.4	0	133	107	0	35	34	34
2025	11	2	0	32	15	25.4	-3.2	1.035	0.5	0.4	0	41.7	31.4	0	132	106	0	35	33	34
2025	11	2	0	42	15	25.3	-2.5	1.035	0.5	0.5	0	41.7	31	0	132	106	0	35	34	35
2025	11	2	0	52	15	25.7	-2.9	1.035	0.4	0.3	0	41.7	31	0	132	106	0	35	34	35
2025	11	2	1	2	15	25.8	-2.6	1.035	0.4	0.3	0	41.7	31	0	132	106	0	35	34	35
2025	11	2	1	12	15	25.4	-3.6	1.035	0.4	0.3	0	41.3	31	0	131	105	0	35	33	35
2025	11	2	1	22	15	25.7	-3.3	1.035	0.3	0.2	0	41.7	31	0	132	106	0	35	34	35
2025	11	2	1	32	15	25.1	-2.3	1.035	0.3	0.2	0	41.7	31	0	132	106	0	35	34	35
2025	11	2	1	42	15	25	-3.3	1.035	0.5	0.4	0	41.7	31.4	0	132	106	0	35	33	35
2025	11	2	1	52	15	24.9	-3.5	1.035	0.3	0.2	0	41.7	31	0	132	106	0	35	34	35
2025	11	2	2	2	15	24.4	-2.9	1.035	0.3	0.2	0	41.7	31	0	131	106	0	34	34	35
2025	11	2	2	12	15	25.2	-3	1.035	0.5	0.4	0	41.7	31.4	0	132	106	0	35	33	35
2025	11	2	2	22	15	24.5	-2.9	1.035	0.4	0.3	0	42.1	31	0	132	106	0	34	34	35
2025	11	2	2	32	15	25	-3.2	1.035	0.5	0.4	0	41.3	31	0	131	105	0	35	33	34
2025	11	2	2	42	15	25.3	-2.3	1.035	0.5	0.4	0	41.3	31	0	131	106	0	35	34	35
2025	11	2	2	52	15	24.9	-3	1.035	0.4	0.3	0	41.7	30.5	0	131	105	0	34	34	34
2025	11	2	3	2	15	25.8	-3.9	1.035	0.4	0.3	0	41.3	31.4	0	131	106	0	35	33	34
2025	11	2	3	12	15	25.8	-2.9	1.035	0.5	0.5	0	41.7	31	0	132	106	0	35	34	34
2025	11	2	3	22	15	23.3	-3.4	1.035	0.5	0.4	0	41.3	31	0	131	106	0	35	34	34
2025	11	2	3	32	15	25.4	-2.5	1.035	0.4	0.3	0	42.1	30.5	0	133	105	0	35	34	35
2025	11	2	3	42	15	24.9	-2.9	1.035	0.5	0.4	0	42.1	31	0	133	105	0	35	33	34
2025	11	2	3	52	15	24.3	-3.9	1.035	0.3	0.2	0	42.6	30.5	0	134	105	0	35	34	34
2025	11	2	4	2	15	25.5	-3.2	1.035	0.3	0.2	0	42.1	30.5	0	133	105	0	35	34	35
2025	11	2	4	12	15	25.1	-2.6	1.035	0.4	0.3	0	42.6	30.5	0	133	105	0	34	34	35
2025	11	2	4	22	15	24.8	-3.1	1.035	0.4	0.3	0	42.1	30.5	0	133	105	0	35	34	34
2025	11	2	4	32	15	23.3	-2.2	1.035	0.5	0.4	0	42.1	31	0	133	106	0	35	34	35
2025	11	2	4	42	15	25.3	-3.4	1.035	0.5	0.4	0	42.1	30.5	0	133	105	0	35	34	34
2025	11	2	4	52	15	25.2	-1.2	1.035	0.4	0.3	0	41.7	31	0	132	105	0	35	33	35
2025	11	2	5	2	15	25.1	-4.1	1.035	0.5	0.4	0	40.4	31	0	129	106	0	35	34	35
2025	11	2	5	12	15	24.9	-2.5	1.035	0.3	0.2	0	42.6	30.5	0	133	105	0	34	34	35
2025	11	2	5	22	15	25.6	-2.6	1.035	0.3	0.2	0	41.7	30.1	0	132	104	0	35	34	35
2025	11	2	5	32	15	26.1	-3.6	1.035	0.4	0.3	0	41.7	30.5	0	132	105	0	35	34	34
2025	11	2	5	42	15	23.8	-3.5	1.035	0.3	0.2	0	42.1	30.5	0	133	105	0	35	34	35
2025	11	2	5	52	15	24.8	-2.3	1.035	0.5	0.4	0	42.6	31	0	134	106	0	35	34	34
2025	11	2	6	2	15	24.6	-2.5	1.035	0.3	0.2	0	42.1	31	0	133	106	0	35	34	34
2025	11	2	6	12	15	25.1	-2.9	1.035	0.4	0.3	0	42.1	31	0	133	106	0	35	34	34
2025	11	2	6	22	15	25	-2.7	1.035	0.5	0.4	0	42.1	31	0	133	106	0	35	34	35
2025	11	2	6	32	15	24.2	-2.9	1.035	0.3	0.2	0	42.1	30.1	0	132	105	0	34	35	34
2025	11	2	6	42	15	24.5	-2.1	1.035	0.3	0.2	0	41.7	31	0	132	105	0	35	33	34
2025	11	2	6	52	15	25.4	-3.1	1.035	0.4	0.3	0	41.3	30.5	0	131	105	0	35	34	34
2025	11	2	7	2	15	24.9	-3.8	1.035	0.4	0.3	0	41.3	30.1	0	131	104	0	35	34	34
2025	11	2	7	12	15	25.6	-3.7	1.035	0.5	0.4	0	40.9	30.1	0	130	103	0	35	33	34
2025	11	2	7	22	15	24.2	-2.9	1.035	0.4	0.3	0	40.9	29.7	0	130	103	0	35	34	35
2025	11	2	7	32	15	24.5	-2.5	1.035	0.5	0.4	0	41.3	30.1	0	131	104	0	35	34	35
2025	11	2	7	42	15	25.9	-2.6	1.035	0.3	0.2	0	40.4	29.2	0	129	102	0	35	34	35
2025	11	2	7	52	15	25.5	-2.3	1.035	0.4	0.3	0	40.9	29.2	0	129	102	0	34	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	2	8	2	15	25.1	-2.8	1.035	0.4	0.3	0	40.4	29.7	0	129	103	0	35	34	35
2025	11	2	8	12	15	25.9	-3	1.035	0.3	0.2	0	40.4	29.7	0	129	103	0	35	34	34
2025	11	2	8	22	15	24.6	-3.1	1.035	0.4	0.3	0	40.4	29.2	0	129	102	0	35	34	35
2025	11	2	8	32	15	25.5	-3.3	1.035	0.3	0.2	0	40.4	29.2	0	129	102	0	35	34	34
2025	11	2	8	42	15	24.2	-3.7	1.036	0.4	0.3	0	40	29.2	0	128	102	0	35	34	34
2025	11	2	8	52	15	25.6	-3.8	1.036	0.4	0.3	0	40	29.2	0	127	102	0	34	34	35
2025	11	2	9	2	15	24.3	-2.5	1.035	0.5	0.4	0	40.4	29.7	0	129	103	0	35	34	34
2025	11	2	9	12	15	25.8	-2.5	1.036	0.4	0.3	0	40	28.8	0	128	101	0	35	34	35
2025	11	2	9	22	15	25.1	-2.9	1.036	0.4	0.3	0	40	29.2	0	128	102	0	35	34	35
2025	11	2	9	32	15	25	-2.6	1.036	0.4	0.3	0	40	29.2	0	128	102	0	35	34	35
2025	11	2	9	42	15	24.7	-3.1	1.036	0.4	0.3	0	39.6	28.4	0	127	100	0	35	34	34
2025	11	2	9	52	15	25.1	-3	1.036	0.4	0.3	0	39.6	28.8	0	127	101	0	35	34	35
2025	11	2	10	2	15	25.3	-4.1	1.036	0.4	0.3	0	40	28.8	0	128	101	0	35	34	35
2025	11	2	10	12	15	24.7	-3.5	1.036	0.3	0.2	0	39.6	28.8	0	127	101	0	35	34	35
2025	11	2	10	22	15	24.6	-3.5	1.036	0.5	0.4	0	40	29.2	0	128	102	0	35	34	35
2025	11	2	10	32	15	25.9	-3.2	1.036	0.3	0.2	0	39.6	28.8	0	127	101	0	35	34	34
2025	11	2	10	42	15	25.7	-2.4	1.036	0.5	0.4	0	40	29.2	0	128	102	0	35	34	35
2025	11	2	10	52	15	24.9	-2.7	1.036	0.4	0.3	0	40	29.2	0	128	102	0	35	34	35
2025	11	2	11	2	15	24.8	-3.6	1.036	0.5	0.4	0	40	29.2	0	128	102	0	35	34	35
2025	11	2	11	12	15	26.5	-2.9	1.036	0.3	0.2	0	40	29.7	0	128	102	0	35	33	35
2025	11	2	11	22	15	24.9	-2.5	1.036	0.5	0.4	0	40	29.7	0	128	102	0	35	33	34
2025	11	2	11	32	15	25.5	-3.6	1.036	0.4	0.3	0	39.1	28.4	0	126	100	0	35	34	34
2025	11	2	11	42	15	25.5	-3.1	1.036	0.5	0.4	0	39.1	28.8	0	126	101	0	35	34	35
2025	11	2	11	52	15	24.8	-3	1.036	0.3	0.2	0	39.6	29.7	0	127	102	0	35	33	34
2025	11	2	12	2	15	25.7	-4.1	1.036	0.5	0.4	0	40	28.8	0	127	101	0	34	34	34
2025	11	2	12	12	15	24.9	-2.7	1.036	0.5	0.4	0	38.7	28.8	0	125	100	0	35	33	35
2025	11	2	12	22	15	25.7	-2.5	1.036	0.5	0.4	0	40	29.7	0	128	103	0	35	34	35
2025	11	2	12	32	15	26.6	-3.8	1.036	0.4	0.3	0	40.4	30.5	0	129	104	0	35	33	34
2025	11	2	12	42	15	25.7	-2.7	1.035	0.4	0.3	0	40.9	30.5	0	130	104	0	35	33	35
2025	11	2	12	52	15	24	-2.6	1.034	0.4	0.3	0	40.9	30.1	0	129	103	0	34	33	35
2025	11	2	13	2	15	25.1	-2.6	1.035	0.5	0.4	0	40	30.1	0	128	103	0	35	33	35
2025	11	2	13	12	15	25.1	-2.6	1.034	0.4	0.3	0	40.4	29.2	0	128	102	0	34	34	35
2025	11	2	13	22	15	24.6	-2.1	1.034	0.3	0.2	0	40	29.2	0	127	101	0	34	33	35
2025	11	2	13	32	15	24	-2.7	1.034	0.4	0.3	0	39.1	28.8	0	126	101	0	35	34	35
2025	11	2	13	42	15	24.7	-2.8	1.034	0.3	0.2	0	39.1	28.8	0	126	101	0	35	34	34
2025	11	2	13	52	15	25.3	-2.4	1.034	0.3	0.2	0	39.1	28.8	0	125	100	0	34	33	35
2025	11	2	14	2	15	25	-3.3	1.034	0.3	0.2	0	39.1	28.8	0	126	101	0	35	34	35
2025	11	2	14	12	15	24.9	-2	1.034	0.5	0.5	0	39.6	28.8	0	127	101	0	35	34	35
2025	11	2	14	22	15	24.2	-2.8	1.034	0.5	0.4	0	39.6	29.2	0	127	102	0	35	34	35
2025	11	2	14	32	15	23.9	-2.8	1.034	0.4	0.3	0	40	29.2	0	128	102	0	35	34	34
2025	11	2	14	42	15	24.5	-2.9	1.035	0.4	0.3	0	40	29.2	0	127	102	0	34	34	34
2025	11	2	14	52	15	24.9	-2.6	1.034	0.4	0.3	0	40	29.7	0	127	102	0	34	33	34
2025	11	2	15	2	15	25.1	-1.1	1.034	0.4	0.3	0	39.6	29.2	0	127	102	0	35	34	34
2025	11	2	15	12	15	24.3	-3	1.034	0.4	0.3	0	39.6	29.7	0	127	102	0	35	33	35
2025	11	2	15	22	15	24.6	-2.6	1.035	0.4	0.3	0	40	30.1	0	128	103	0	35	33	35
2025	11	2	15	32	15	23.9	-3.9	1.034	0.3	0.2	0	40	30.1	0	128	103	0	35	33	34
2025	11	2	15	42	15	25.4	-2.1	1.034	0.5	0.4	0	39.6	29.7	0	127	102	0	35	33	34
2025	11	2	15	52	15	24.2	-2	1.034	0.4	0.3	0	40.9	30.1	0	130	104	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	2	16	2	15	23.7	-3	1.033	0.3	0.2	0	40.4	30.1	0	129	104	0	35	34	35
2025	11	2	16	12	15	24.6	-2.7	1.034	0.4	0.3	0	40.9	30.5	0	129	104	0	34	33	34
2025	11	2	16	22	15	24.6	-2.1	1.033	0.3	0.2	0	39.6	28.8	0	127	101	0	35	34	35
2025	11	2	16	32	15	25.4	-3.5	1.033	0.4	0.3	0	39.6	29.2	0	127	101	0	35	33	34
2025	11	2	16	42	15	24.4	-3.4	1.033	0.5	0.4	0	40	29.2	0	127	102	0	34	34	35
2025	11	2	16	52	15	25.3	-2.8	1.033	0.4	0.3	0	40	29.7	0	128	102	0	35	33	34
2025	11	2	17	2	15	25.5	-3.1	1.033	0.5	0.4	0	39.6	29.2	0	127	101	0	35	33	35
2025	11	2	17	12	15	25.7	-3.2	1.033	0.3	0.2	0	39.6	28.8	0	127	101	0	35	34	34
2025	11	2	17	22	15	26.3	-3.1	1.033	0.3	0.2	0	39.6	28.4	0	127	101	0	35	35	35
2025	11	2	17	32	15	25.4	-2.5	1.033	0.4	0.3	0	40.4	29.2	0	128	101	0	34	33	34
2025	11	2	17	42	15	26.9	-3	1.034	0.5	0.4	0	40.4	29.7	0	128	102	0	34	33	34
2025	11	2	17	52	15	26.1	-3.6	1.033	0.4	0.3	0	41.3	29.2	0	130	102	0	34	34	34
2025	11	2	18	2	15	25	-2.6	1.033	0.4	0.3	0	41.3	30.5	0	131	104	0	35	33	35
2025	11	2	18	12	15	26.1	-3	1.034	0.4	0.3	0	40.9	30.5	0	130	104	0	35	33	35
2025	11	2	18	22	15	25.3	-3.8	1.034	0.4	0.3	0	41.3	30.1	0	131	104	0	35	34	34
2025	11	2	18	32	15	26.8	-3.3	1.034	0.5	0.4	0	41.3	30.1	0	131	103	0	35	33	34
2025	11	2	18	42	15	25.8	-3.1	1.033	0.4	0.3	0	41.7	30.1	0	131	104	0	34	34	35
2025	11	2	18	52	15	25.5	-2.5	1.034	0.5	0.4	0	41.7	30.5	0	132	105	0	35	34	34
2025	11	2	19	2	15	26	-3.3	1.034	0.4	0.3	0	42.1	31	0	133	106	0	35	34	35
2025	11	2	19	12	15	26.5	-2.3	1.034	0.5	0.4	0	41.7	30.5	0	132	105	0	35	34	35
2025	11	2	19	22	15	24.4	-2.6	1.034	0.3	0.2	0	42.1	31.4	0	133	106	0	35	33	35
2025	11	2	19	32	15	26	-3.9	1.034	0.5	0.4	0	41.7	31	0	132	105	0	35	33	35
2025	11	2	19	42	15	24.6	-3.4	1.035	0.4	0.3	0	42.1	31	0	132	106	0	34	34	35
2025	11	2	19	52	15	24.1	-3.2	1.035	0.4	0.3	0	42.6	31	0	134	106	0	35	34	35
2025	11	2	20	2	15	24.8	-2.3	1.034	0.4	0.3	0	43	31.8	0	134	107	0	34	33	34
2025	11	2	20	12	15	24.7	-2.4	1.034	0.3	0.2	0	42.1	31	0	133	106	0	35	34	34
2025	11	2	20	22	15	25.2	-2.9	1.035	0.5	0.4	0	40.4	31	0	129	106	0	35	34	35
2025	11	2	20	32	15	25.4	-3	1.035	0.5	0.4	0	42.6	31.4	0	134	106	0	35	33	34
2025	11	2	20	42	15	25.1	-3.8	1.035	0.3	0.2	0	42.1	31.4	0	133	106	0	35	33	35
2025	11	2	20	52	15	26.8	-3.6	1.035	0.4	0.3	0	42.1	30.5	0	133	105	0	35	34	34
2025	11	2	21	2	15	24.6	-3.2	1.035	0.3	0.2	0	42.1	31	0	133	106	0	35	34	34
2025	11	2	21	12	15	24.4	-2.7	1.035	0.4	0.3	0	42.1	31	0	133	106	0	35	34	35
2025	11	2	21	22	15	25.6	-3.1	1.035	0.4	0.3	0	42.1	31	0	133	106	0	35	34	34
2025	11	2	21	32	15	25	-2.8	1.035	0.4	0.3	0	42.1	31.4	0	133	106	0	35	33	35
2025	11	2	21	42	15	25.4	-4.4	1.035	0.4	0.3	0	41.7	30.5	0	132	105	0	35	34	34
2025	11	2	21	52	15	24.5	-3.9	1.035	0.5	0.4	0	42.1	31	0	133	106	0	35	34	35
2025	11	2	22	2	15	25.5	-3.7	1.035	0.5	0.4	0	42.6	31.4	0	133	106	0	34	33	35
2025	11	2	22	12	15	25.1	-2.3	1.035	0.4	0.3	0	42.1	31	0	133	106	0	35	34	35
2025	11	2	22	22	15	26.8	-3.2	1.035	0.4	0.3	0	42.1	30.5	0	133	105	0	35	34	34
2025	11	2	22	32	15	25.8	-3.4	1.035	0.3	0.2	0	41.7	30.5	0	132	105	0	35	34	35
2025	11	2	22	42	15	25.2	-3	1.035	0.3	0.2	0	43	31.4	0	134	106	0	34	33	35
2025	11	2	22	52	15	24.5	-3.1	1.035	0.5	0.4	0	42.1	31.4	0	133	106	0	35	33	34
2025	11	2	23	2	15	24.6	-3.3	1.035	0.5	0.4	0	42.1	31	0	133	106	0	35	34	35
2025	11	2	23	12	15	24	-2.6	1.035	0.3	0.2	0	42.1	31.4	0	133	106	0	35	33	34
2025	11	2	23	22	15	24.6	-2.6	1.035	0.4	0.3	0	42.6	31	0	133	106	0	34	34	35
2025	11	2	23	32	15	25	-2.8	1.035	0.5	0.5	0	42.1	31	0	133	106	0	35	34	34
2025	11	2	23	42	15	25.3	-3.9	1.035	0.4	0.3	0	42.1	31	0	133	106	0	35	34	35
2025	11	2	23	52	15	25.5	-3.5	1.035	0.4	0.3	0	42.1	30.5	0	133	105	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	3	0	2	15	25.3	-2.9	1.035	0.4	0.3	0	41.7	31	0	132	106	0	35	34	34
2025	11	3	0	12	15	25	-2.9	1.035	0.4	0.3	0	41.7	30.5	0	132	105	0	35	34	34
2025	11	3	0	22	15	24.4	-2.4	1.035	0.4	0.3	0	42.1	31	0	133	106	0	35	34	34
2025	11	3	0	32	15	25.4	-3.8	1.035	0.4	0.3	0	42.1	31	0	133	106	0	35	34	35
2025	11	3	0	42	15	24.4	-2.5	1.035	0.3	0.2	0	42.1	31.4	0	133	106	0	35	33	35
2025	11	3	0	52	15	25.4	-2.8	1.035	0.3	0.2	0	42.1	30.5	0	132	105	0	34	34	34
2025	11	3	1	2	15	25.4	-3	1.035	0.4	0.3	0	41.7	30.5	0	132	105	0	35	34	34
2025	11	3	1	12	15	25.5	-3	1.035	0.4	0.3	0	42.1	30.5	0	132	105	0	34	34	34
2025	11	3	1	22	15	24.5	-2.8	1.034	0.4	0.3	0	41.7	30.5	0	132	105	0	35	34	34
2025	11	3	1	32	15	24.9	-2.1	1.034	0.3	0.2	0	41.7	31.4	0	132	106	0	35	33	34
2025	11	3	1	42	15	25.4	-2.9	1.034	0.4	0.3	0	41.7	30.5	0	132	105	0	35	34	34
2025	11	3	1	52	15	24.6	-3.1	1.035	0.5	0.4	0	41.7	30.5	0	132	105	0	35	34	35
2025	11	3	2	2	15	24.4	-2.4	1.035	0.4	0.3	0	41.7	30.5	0	132	105	0	35	34	35
2025	11	3	2	12	15	24.9	-2.5	1.035	0.3	0.2	0	41.7	30.5	0	132	105	0	35	34	34
2025	11	3	2	22	15	24.1	-2.1	1.035	0.5	0.4	0	41.7	30.5	0	132	105	0	35	34	35
2025	11	3	2	32	15	24.5	-3.2	1.034	0.5	0.4	0	41.7	30.5	0	132	105	0	35	34	34
2025	11	3	2	42	15	24.9	-2.5	1.034	0.4	0.3	0	41.7	30.5	0	132	105	0	35	34	35
2025	11	3	2	52	15	25.8	-2.7	1.034	0.5	0.4	0	41.7	30.1	0	132	105	0	35	35	35
2025	11	3	3	2	15	24.8	-2.8	1.034	0.5	0.4	0	41.7	30.5	0	132	105	0	35	34	34
2025	11	3	3	12	15	23.2	-2.7	1.034	0.5	0.4	0	41.7	31	0	132	106	0	35	34	35
2025	11	3	3	22	15	25.1	-2.8	1.034	0.5	0.4	0	41.7	30.5	0	132	105	0	35	34	34
2025	11	3	3	32	15	25.1	-3.4	1.034	0.4	0.3	0	41.7	31	0	132	105	0	35	33	34
2025	11	3	3	42	15	25.3	-2.6	1.034	0.5	0.4	0	41.3	30.5	0	131	104	0	35	33	35
2025	11	3	3	52	15	25.3	-2.9	1.034	0.5	0.4	0	41.3	30.5	0	131	104	0	35	33	34
2025	11	3	4	2	15	24.9	-3	1.034	0.5	0.5	0	41.7	30.5	0	132	105	0	35	34	35
2025	11	3	4	12	15	25	-2.1	1.034	0.4	0.3	0	40.9	31	0	131	105	0	36	33	35
2025	11	3	4	22	15	25.6	-2.9	1.034	0.4	0.3	0	41.3	30.1	0	131	104	0	35	34	34
2025	11	3	4	32	15	26.2	-3.8	1.034	0.5	0.5	0	41.3	30.1	0	131	104	0	35	34	34
2025	11	3	4	42	15	24.2	-3.5	1.034	0.3	0.2	0	41.3	30.1	0	131	104	0	35	34	35
2025	11	3	4	52	15	25.2	-3.2	1.034	0.5	0.5	0	41.3	30.5	0	131	105	0	35	34	35
2025	11	3	5	2	15	25.8	-2.9	1.034	0.4	0.3	0	40.9	30.5	0	131	104	0	36	33	35
2025	11	3	5	12	15	26.2	-3.4	1.034	0.3	0.2	0	41.3	30.5	0	131	105	0	35	34	34
2025	11	3	5	22	15	25.4	-3.8	1.034	0.3	0.2	0	41.3	30.5	0	131	104	0	35	33	34
2025	11	3	5	32	15	25.1	-3.4	1.035	0.5	0.5	0	41.3	31	0	131	105	0	35	33	35
2025	11	3	5	42	15	25.4	-3.1	1.035	0.5	0.4	0	41.7	31	0	132	106	0	35	34	34
2025	11	3	5	52	15	24.2	-2.3	1.035	0.4	0.3	0	41.7	31	0	132	106	0	35	34	35
2025	11	3	6	2	15	25.8	-2.6	1.034	0.5	0.5	0	41.7	31	0	131	105	0	34	33	34
2025	11	3	6	12	15	25.6	-2.9	1.035	0.4	0.3	0	42.1	30.5	0	132	106	0	34	35	35
2025	11	3	6	22	15	24.5	-3.3	1.035	0.5	0.4	0	41.7	30.5	0	132	106	0	35	35	34
2025	11	3	6	32	15	25.9	-3.3	1.035	0.4	0.3	0	42.1	31.4	0	132	106	0	34	33	35
2025	11	3	6	42	15	24.8	-3.6	1.035	0.3	0.2	0	41.7	31	0	132	106	0	35	34	34
2025	11	3	6	52	15	25	-2.2	1.035	0.5	0.4	0	41.3	31	0	131	105	0	35	33	34
2025	11	3	7	2	15	24.2	-2.8	1.035	0.3	0.2	0	40.9	29.7	0	130	103	0	35	34	34
2025	11	3	7	12	15	25.3	-4	1.035	0.4	0.3	0	40.9	30.1	0	129	103	0	34	33	34
2025	11	3	7	22	15	24.7	-2.5	1.035	0.4	0.3	0	40.4	29.7	0	129	103	0	35	34	34
2025	11	3	7	32	15	24.2	-3.3	1.035	0.4	0.3	0	40	29.7	0	128	102	0	35	33	34
2025	11	3	7	42	15	27.8	-2.8	1.035	0.4	0.3	0	40	28.8	0	128	101	0	35	34	35
2025	11	3	7	52	15	24.6	-2.3	1.035	0.4	0.3	0	39.6	28.4	0	127	100	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	3	8	2	15	24.2	-2.9	1.035	0.4	0.3	0	39.6	29.2	0	127	101	0	35	33	34
2025	11	3	8	12	15	25.5	-3.3	1.035	0.5	0.5	0	39.6	28.8	0	127	101	0	35	34	34
2025	11	3	8	22	15	24.7	-2.2	1.035	0.3	0.2	0	39.6	28.8	0	127	101	0	35	34	34
2025	11	3	8	32	15	24.6	-2.5	1.035	0.5	0.4	0	39.6	29.2	0	128	102	0	36	34	34
2025	11	3	8	42	15	24.9	-3	1.035	0.5	0.4	0	39.1	29.2	0	127	102	0	36	34	34
2025	11	3	8	52	15	26.4	-3.3	1.035	0.4	0.3	0	39.1	28.8	0	126	101	0	35	34	34
2025	11	3	9	2	15	25	-3	1.035	0.5	0.4	0	39.1	28.8	0	126	101	0	35	34	35
2025	11	3	9	12	15	25	-2	1.035	0.4	0.3	0	39.1	28	0	126	100	0	35	35	34
2025	11	3	9	22	15	26.1	-3.1	1.035	0.4	0.3	0	38.7	28.4	0	125	100	0	35	34	34
2025	11	3	9	32	15	26.5	-2.4	1.036	0.5	0.4	0	39.1	28.8	0	126	100	0	35	33	35
2025	11	3	9	42	15	25.7	-2.7	1.036	0.4	0.3	0	38.7	28	0	125	99	0	35	34	35
2025	11	3	9	52	15	26.3	-3	1.036	0.4	0.3	0	38.3	28.8	0	125	100	0	36	33	34
2025	11	3	10	2	15	25.5	-2.2	1.036	0.4	0.3	0	38.3	28.4	0	124	99	0	35	33	35
2025	11	3	10	12	15	24.5	-3.1	1.036	0.5	0.5	0	38.7	28.4	0	125	100	0	35	34	34
2025	11	3	10	22	15	25.3	-2.9	1.036	0.5	0.4	0	38.7	28.4	0	124	99	0	34	33	34
2025	11	3	10	32	15	25.4	-2.9	1.036	0.4	0.3	0	38.7	28.8	0	125	100	0	35	33	34
2025	11	3	10	42	15	25.1	-3	1.036	0.4	0.3	0	39.1	28	0	125	99	0	34	34	34
2025	11	3	10	52	15	25	-2.8	1.036	0.3	0.2	0	38.3	28	0	124	99	0	35	34	34
2025	11	3	11	2	15	25.2	-3.7	1.037	0.5	0.4	0	38.7	28.4	0	125	100	0	35	34	35
2025	11	3	11	12	15	26	-2.6	1.037	0.3	0.2	0	39.1	28.8	0	126	101	0	35	34	35
2025	11	3	11	22	15	25.6	-2.4	1.037	0.3	0.2	0	39.1	28.4	0	125	100	0	34	34	35
2025	11	3	11	32	15	26.5	-3	1.037	0.4	0.3	0	39.1	29.2	0	126	101	0	35	33	35
2025	11	3	11	42	15	25.7	-3.4	1.037	0.4	0.3	0	38.7	28.4	0	125	100	0	35	34	35
2025	11	3	11	52	15	25.7	-3.5	1.037	0.5	0.4	0	38.7	28	0	125	99	0	35	34	35
2025	11	3	12	2	15	25.9	-3.4	1.037	0.5	0.4	0	39.1	28.8	0	126	101	0	35	34	35
2025	11	3	12	12	15	24.5	-3.1	1.037	0.5	0.4	0	38.7	28.4	0	125	100	0	35	34	34
2025	11	3	12	22	15	24.4	-2.9	1.037	0.5	0.4	0	39.1	29.2	0	126	101	0	35	33	35
2025	11	3	12	32	15	24.1	-2.5	1.037	0.5	0.4	0	38.7	28	0	125	99	0	35	34	34
2025	11	3	12	42	15	25.4	-3.7	1.037	0.5	0.4	0	38.3	28.4	0	124	99	0	35	33	34
2025	11	3	12	52	15	25.5	-2.1	1.037	0.5	0.4	0	39.1	29.2	0	126	101	0	35	33	34
2025	11	3	13	2	15	24.2	-3.1	1.037	0.3	0.2	0	40.9	29.7	0	129	103	0	34	34	34
2025	11	3	13	12	15	25.2	-2.6	1.036	0.4	0.3	0	39.6	28.4	0	127	101	0	35	35	34
2025	11	3	13	22	15	25.2	-3	1.036	0.3	0.2	0	38.7	27.5	0	125	99	0	35	35	34
2025	11	3	13	32	15	23.7	-2.8	1.034	0.4	0.3	0	39.1	28.8	0	126	101	0	35	34	34
2025	11	3	13	42	15	24.6	-4.2	1.035	0.4	0.3	0	38.7	28.4	0	125	100	0	35	34	35
2025	11	3	13	52	15	24.5	-1.9	1.035	0.5	0.4	0	39.1	29.2	0	126	101	0	35	33	34
2025	11	3	14	2	15	24.8	-3.2	1.035	0.5	0.4	0	39.1	28.8	0	125	100	0	34	33	35
2025	11	3	14	12	15	23.1	-3	1.035	0.4	0.3	0	39.1	29.2	0	126	102	0	35	34	34
2025	11	3	14	22	15	26	-2.1	1.035	0.3	0.2	0	38.7	28.8	0	125	101	0	35	34	34
2025	11	3	14	32	15	25.7	-2.5	1.035	0.5	0.4	0	39.6	29.7	0	127	102	0	35	33	34
2025	11	3	14	42	15	25.3	-2.5	1.035	0.4	0.3	0	39.1	29.2	0	126	101	0	35	33	34
2025	11	3	14	52	15	24.3	-2.5	1.035	0.3	0.2	0	39.1	28.8	0	126	101	0	35	34	34
2025	11	3	15	2	15	24.9	-2.6	1.034	0.6	0.5	0	39.1	29.2	0	126	101	0	35	33	34
2025	11	3	15	12	15	26.3	-3.1	1.034	0.4	0.3	0	39.6	29.7	0	127	102	0	35	33	34
2025	11	3	15	22	15	24.6	-1.6	1.034	0.5	0.4	0	40.4	30.5	0	129	104	0	35	33	35
2025	11	3	15	32	15	24.8	-3.2	1.034	0.3	0.2	0	40.4	30.1	0	129	104	0	35	34	35
2025	11	3	15	42	15	24.7	-3.3	1.034	0.3	0.2	0	40	30.1	0	128	103	0	35	33	34
2025	11	3	15	52	15	24.3	-2.7	1.034	0.5	0.4	0	39.6	29.7	0	127	102	0	35	33	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	3	16	2	15	24.7	-2.6	1.034	0.4	0.3	0	40	29.7	0	127	102	0	34	33	34
2025	11	3	16	12	15	25.6	-2.2	1.034	0.4	0.3	0	40	29.7	0	128	103	0	35	34	34
2025	11	3	16	22	15	24.4	-2.5	1.034	0.5	0.4	0	39.6	29.2	0	127	102	0	35	34	35
2025	11	3	16	32	15	25	-3.6	1.035	0.5	0.4	0	39.1	29.2	0	126	101	0	35	33	33
2025	11	3	16	42	15	25.5	-3.3	1.036	0.3	0.2	0	39.1	28.8	0	126	101	0	35	34	34
2025	11	3	16	52	15	26.2	-4.3	1.036	0.5	0.4	0	39.6	28.8	0	126	100	0	34	33	34
2025	11	3	17	2	15	25	-3.6	1.036	0.3	0.2	0	38.7	28.4	0	125	100	0	35	34	34
2025	11	3	17	12	15	24.8	-2.6	1.036	0.3	0.2	0	40	29.2	0	128	102	0	35	34	35
2025	11	3	17	22	15	25.9	-3	1.036	0.4	0.3	0	39.6	29.2	0	127	101	0	35	33	35
2025	11	3	17	32	15	25	-2.8	1.036	0.5	0.4	0	40	29.2	0	128	102	0	35	34	34
2025	11	3	17	42	15	26.2	-2.5	1.036	0.5	0.4	0	39.6	29.2	0	127	101	0	35	33	35
2025	11	3	17	52	15	25.3	-3.3	1.036	0.4	0.3	0	39.6	29.2	0	127	101	0	35	33	34
2025	11	3	18	2	15	24.8	-2.8	1.036	0.5	0.4	0	40.4	29.7	0	129	103	0	35	34	35
2025	11	3	18	12	15	24.8	-2.8	1.037	0.5	0.4	0	40.9	29.7	0	129	103	0	34	34	34
2025	11	3	18	22	15	25.2	-2.7	1.036	0.3	0.2	0	40.9	30.1	0	130	104	0	35	34	35
2025	11	3	18	32	15	24.3	-2.1	1.036	0.3	0.2	0	40.9	30.5	0	130	104	0	35	33	35
2025	11	3	18	42	15	25.1	-3.4	1.036	0.4	0.3	0	40.9	30.1	0	130	104	0	35	34	34
2025	11	3	18	52	15	24.9	-4.2	1.036	0.4	0.3	0	41.3	30.5	0	131	105	0	35	34	34
2025	11	3	19	2	15	25.7	-3.2	1.036	0.3	0.2	0	41.7	30.1	0	131	104	0	34	34	35
2025	11	3	19	12	15	25.6	-3	1.036	0.5	0.4	0	40.9	30.5	0	130	104	0	35	33	34
2025	11	3	19	22	15	25.2	-2.7	1.036	0.5	0.4	0	41.3	30.1	0	131	104	0	35	34	34
2025	11	3	19	32	15	26	-3.5	1.036	0.5	0.4	0	41.3	30.5	0	131	104	0	35	33	34
2025	11	3	19	42	15	26.4	-3	1.036	0.4	0.3	0	41.3	31	0	131	105	0	35	33	34
2025	11	3	19	52	15	25.4	-3.5	1.036	0.4	0.3	0	41.7	31	0	131	105	0	34	33	34
2025	11	3	20	2	15	24.2	-2	1.036	0.4	0.3	0	41.7	30.5	0	131	105	0	34	34	34
2025	11	3	20	12	15	24.8	-3.4	1.036	0.3	0.2	0	41.3	30.1	0	130	104	0	34	34	34
2025	11	3	20	22	15	26.2	-3.3	1.036	0.5	0.5	0	40.9	31	0	130	105	0	35	33	34
2025	11	3	20	32	15	25.6	-3.9	1.036	0.4	0.3	0	41.3	31.4	0	131	106	0	35	33	34
2025	11	3	20	42	15	25	-2.5	1.036	0.5	0.4	0	41.3	31	0	131	106	0	35	34	35
2025	11	3	20	52	15	26.3	-2.8	1.036	0.3	0.2	0	40.9	30.5	0	130	104	0	35	33	35
2025	11	3	21	2	15	25.5	-3.2	1.036	0.3	0.2	0	41.7	30.5	0	131	105	0	34	34	35
2025	11	3	21	12	15	26.2	-3.2	1.036	0.5	0.4	0	40.9	30.1	0	130	104	0	35	34	35
2025	11	3	21	22	15	24.6	-3	1.036	0.5	0.4	0	41.7	31.4	0	132	106	0	35	33	34
2025	11	3	21	32	15	25.7	-3.2	1.036	0.3	0.2	0	42.1	31.4	0	133	107	0	35	34	34
2025	11	3	21	42	15	25	-2.5	1.036	0.4	0.3	0	41.7	30.5	0	131	105	0	34	34	34
2025	11	3	21	52	15	24.9	-3	1.036	0.4	0.3	0	41.7	30.5	0	131	105	0	34	34	35
2025	11	3	22	2	15	25.9	-2.9	1.036	0.4	0.3	0	40.4	30.1	0	129	104	0	35	34	35
2025	11	3	22	12	15	24.8	-2.3	1.037	0.4	0.3	0	40.9	31	0	130	105	0	35	33	35
2025	11	3	22	22	15	24.3	-2.9	1.036	0.5	0.4	0	41.3	31	0	131	106	0	35	34	34
2025	11	3	22	32	15	25.8	-3	1.036	0.3	0.2	0	40.9	30.5	0	130	105	0	35	34	35
2025	11	3	22	42	15	26.6	-3.3	1.036	0.5	0.4	0	40.9	30.1	0	130	104	0	35	34	35
2025	11	3	22	52	15	23.4	-3.5	1.036	0.4	0.3	0	41.3	30.5	0	131	105	0	35	34	34
2025	11	3	23	2	15	24.2	-2.5	1.036	0.5	0.4	0	41.3	31	0	131	106	0	35	34	35
2025	11	3	23	12	15	24.6	-2.7	1.036	0.4	0.3	0	41.3	30.1	0	131	104	0	35	34	35
2025	11	3	23	22	15	25.4	-1.5	1.036	0.5	0.5	0	40.9	30.5	0	130	105	0	35	34	35
2025	11	3	23	32	15	24.7	-3.3	1.036	0.5	0.5	0	40.4	30.5	0	130	105	0	36	34	34
2025	11	3	23	42	15	25.5	-4.1	1.036	0.4	0.3	0	40.9	30.1	0	130	104	0	35	34	34
2025	11	3	23	52	15	25.8	-3.3	1.036	0.5	0.4	0	40.9	30.5	0	130	105	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	4	0	2	15	24	-3.6	1.036	0.5	0.5	0	40.9	30.1	0	130	104	0	35	34	34
2025	11	4	0	12	15	24.9	-2.4	1.036	0.4	0.3	0	40.9	30.5	0	130	105	0	35	34	34
2025	11	4	0	22	15	25.4	-2.5	1.036	0.4	0.3	0	40.9	30.5	0	130	105	0	35	34	35
2025	11	4	0	32	15	24.1	-2.5	1.036	0.3	0.2	0	40.9	30.5	0	130	105	0	35	34	35
2025	11	4	0	42	15	25.8	-2.7	1.036	0.4	0.3	0	40.9	30.5	0	130	105	0	35	34	35
2025	11	4	0	52	15	24.1	-2.6	1.036	0.3	0.2	0	40.9	30.5	0	130	105	0	35	34	35
2025	11	4	1	2	15	25.7	-2.2	1.036	0.5	0.4	0	41.3	31	0	131	105	0	35	33	34
2025	11	4	1	12	15	25.3	-4.1	1.036	0.3	0.2	0	41.3	30.1	0	130	104	0	34	34	35
2025	11	4	1	22	15	25.5	-4.1	1.036	0.4	0.3	0	40.9	31	0	130	105	0	35	33	34
2025	11	4	1	32	15	23.9	-3.2	1.036	0.5	0.4	0	40.4	30.5	0	130	105	0	36	34	35
2025	11	4	1	42	15	25.8	-3.5	1.036	0.3	0.2	0	40.9	30.1	0	130	104	0	35	34	35
2025	11	4	1	52	15	27	-3.2	1.036	0.6	0.5	0	40.9	30.5	0	130	104	0	35	33	34
2025	11	4	2	2	15	25.3	-3	1.036	0.3	0.2	0	40.9	30.5	0	130	105	0	35	34	34
2025	11	4	2	12	15	24.9	-2.1	1.036	0.3	0.2	0	40.9	30.5	0	130	105	0	35	34	34
2025	11	4	2	22	15	25.5	-3.7	1.036	0.4	0.3	0	41.3	30.1	0	131	104	0	35	34	35
2025	11	4	2	32	15	25.6	-2.8	1.036	0.4	0.3	0	42.1	30.5	0	132	105	0	34	34	35
2025	11	4	2	42	15	24.7	-3.7	1.036	0.5	0.4	0	41.7	30.5	0	133	105	0	36	34	35
2025	11	4	2	52	15	24.9	-2.6	1.036	0.5	0.4	0	42.1	30.5	0	133	105	0	35	34	34
2025	11	4	3	2	15	26.2	-2.1	1.036	0.5	0.4	0	42.1	30.1	0	132	104	0	34	34	35
2025	11	4	3	12	15	24.9	-2.6	1.037	0.4	0.3	0	41.7	30.1	0	132	104	0	35	34	35
2025	11	4	3	22	15	25.2	-3.2	1.036	0.4	0.3	0	41.3	30.5	0	131	105	0	35	34	34
2025	11	4	3	32	15	24.9	-3.6	1.036	0.5	0.4	0	41.3	30.5	0	131	104	0	35	33	34
2025	11	4	3	42	15	25.5	-2.2	1.036	0.4	0.3	0	41.7	31	0	132	105	0	35	33	35
2025	11	4	3	52	15	25	-3.3	1.036	0.4	0.3	0	41.7	30.5	0	132	105	0	35	34	35
2025	11	4	4	2	15	24.6	-2.3	1.037	0.3	0.2	0	41.7	30.5	0	132	105	0	35	34	35
2025	11	4	4	12	15	25.4	-2.5	1.037	0.4	0.3	0	41.7	30.5	0	132	104	0	35	33	35
2025	11	4	4	22	15	25	-3.3	1.036	0.4	0.3	0	42.1	31	0	133	105	0	35	33	35
2025	11	4	4	32	15	24.9	-3.3	1.037	0.5	0.4	0	42.1	30.5	0	133	105	0	35	34	35
2025	11	4	4	42	15	23.4	-3.4	1.037	0.5	0.4	0	42.1	30.5	0	133	105	0	35	34	34
2025	11	4	4	52	15	24.6	-3.1	1.037	0.3	0.2	0	41.7	30.5	0	132	105	0	35	34	34
2025	11	4	5	2	15	25.5	-2.2	1.037	0.5	0.4	0	41.7	30.5	0	132	105	0	35	34	34
2025	11	4	5	12	15	24.8	-3.3	1.037	0.3	0.2	0	41.7	30.1	0	132	104	0	35	34	34
2025	11	4	5	22	15	24.8	-2.3	1.037	0.4	0.3	0	42.1	30.5	0	133	105	0	35	34	34
2025	11	4	5	32	15	25	-3.3	1.037	0.5	0.4	0	42.1	31	0	133	105	0	35	33	34
2025	11	4	5	42	15	24.9	-2.2	1.037	0.5	0.4	0	42.1	30.5	0	133	105	0	35	34	34
2025	11	4	5	52	15	25.1	-2.9	1.037	0.5	0.5	0	41.7	30.1	0	132	104	0	35	34	35
2025	11	4	6	2	15	26.2	-2.9	1.037	0.4	0.3	0	41.3	30.5	0	131	104	0	35	33	35
2025	11	4	6	12	15	24.8	-3.1	1.037	0.5	0.4	0	41.7	30.1	0	132	104	0	35	34	35
2025	11	4	6	22	15	25.8	-2.9	1.037	0.3	0.2	0	41.7	30.1	0	132	104	0	35	34	34
2025	11	4	6	32	15	26	-3.3	1.037	0.4	0.3	0	41.7	30.1	0	132	104	0	35	34	34
2025	11	4	6	42	15	25.2	-3.2	1.037	0.3	0.2	0	41.3	30.1	0	131	104	0	35	34	35
2025	11	4	6	52	15	25	-2.7	1.037	0.5	0.4	0	41.3	30.1	0	131	104	0	35	34	34
2025	11	4	7	2	15	25.8	-3.7	1.037	0.4	0.3	0	41.3	29.7	0	130	103	0	34	34	35
2025	11	4	7	12	15	25	-3.3	1.037	0.5	0.4	0	40.9	29.2	0	130	102	0	35	34	34
2025	11	4	7	22	15	24.6	-2.9	1.037	0.4	0.3	0	41.3	29.7	0	130	103	0	34	34	35
2025	11	4	7	32	15	24.8	-2.8	1.037	0.4	0.3	0	40.4	29.2	0	129	102	0	35	34	35
2025	11	4	7	42	15	23.7	-2.2	1.037	0.4	0.3	0	40.9	29.2	0	129	101	0	34	33	34
2025	11	4	7	52	15	23.9	-3	1.037	0.4	0.3	0	40	28.8	0	128	101	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	4	8	2	15	25.7	-2.5	1.037	0.5	0.4	0	40.9	29.2	0	129	102	0	34	34	35
2025	11	4	8	12	15	24.8	-3.6	1.037	0.4	0.3	0	40	28.8	0	128	101	0	35	34	35
2025	11	4	8	22	15	25.8	-2.6	1.037	0.5	0.4	0	40.4	29.7	0	129	102	0	35	33	35
2025	11	4	8	32	15	25.7	-2.7	1.037	0.3	0.2	0	40.4	29.2	0	129	102	0	35	34	34
2025	11	4	8	42	15	25.5	-2.9	1.037	0.5	0.4	0	40	28.8	0	128	101	0	35	34	35
2025	11	4	8	52	15	24.7	-2.9	1.038	0.3	0.2	0	40	28.8	0	128	101	0	35	34	35
2025	11	4	9	2	15	25.5	-2.1	1.038	0.5	0.4	0	39.1	28.4	0	126	100	0	35	34	34
2025	11	4	9	12	15	25.7	-3.5	1.038	0.5	0.4	0	39.6	28.4	0	126	100	0	34	34	34
2025	11	4	9	22	15	24.2	-3.3	1.038	0.5	0.4	0	39.1	28.8	0	126	100	0	35	33	35
2025	11	4	9	32	15	24.9	-2.5	1.038	0.5	0.4	0	38.7	28.4	0	125	99	0	35	33	34
2025	11	4	9	42	15	25.9	-1.9	1.038	0.3	0.2	0	38.7	28	0	125	98	0	35	33	35
2025	11	4	9	52	15	24.9	-2.2	1.038	0.5	0.4	0	38.7	28	0	125	99	0	35	34	35
2025	11	4	10	2	15	24	-2.6	1.038	0.5	0.4	0	38.7	27.5	0	125	98	0	35	34	35
2025	11	4	10	12	15	24.1	-2.7	1.038	0.5	0.5	0	38.3	27.1	0	124	97	0	35	34	34
2025	11	4	10	22	15	25.1	-3.5	1.038	0.3	0.2	0	37.8	27.1	0	123	97	0	35	34	35
2025	11	4	10	32	15	24.1	-1.4	1.038	0.3	0.2	0	38.3	27.5	0	124	98	0	35	34	35
2025	11	4	10	42	15	24.9	-3	1.038	0.5	0.4	0	39.1	28.4	0	125	99	0	34	33	35
2025	11	4	10	52	15	25.4	-2.5	1.039	0.4	0.3	0	38.3	27.5	0	124	98	0	35	34	34
2025	11	4	11	2	15	23.8	-2.4	1.038	0.5	0.5	0	39.1	28.4	0	126	99	0	35	33	34
2025	11	4	11	12	15	25.6	-2.5	1.039	0.4	0.3	0	38.7	28	0	125	99	0	35	34	34
2025	11	4	11	22	15	25.2	-3.6	1.039	0.3	0.2	0	38.3	27.5	0	124	98	0	35	34	35
2025	11	4	11	32	15	25.6	-3.5	1.039	0.5	0.4	0	38.3	27.5	0	124	98	0	35	34	34
2025	11	4	11	42	15	25	-3.3	1.039	0.4	0.3	0	38.3	27.5	0	124	98	0	35	34	35
2025	11	4	11	52	15	26.3	-2.3	1.039	0.5	0.4	0	38.3	27.5	0	124	97	0	35	33	34
2025	11	4	12	2	15	24.4	-1.9	1.038	0.4	0.3	0	38.7	28	0	124	98	0	34	33	34
2025	11	4	12	12	15	24.9	-2.4	1.038	0.3	0.2	0	38.3	27.5	0	124	98	0	35	34	34
2025	11	4	12	22	15	24.4	-2.5	1.038	0.4	0.3	0	37.8	27.1	0	123	97	0	35	34	35
2025	11	4	12	32	15	25.4	-2.2	1.038	0.4	0.3	0	38.3	26.7	0	123	96	0	34	34	34
2025	11	4	12	42	15	25.4	-3	1.039	0.4	0.3	0	38.3	27.1	0	123	96	0	34	33	34
2025	11	4	12	52	15	26	-3.3	1.039	0.3	0.2	0	37.8	26.7	0	123	96	0	35	34	35
2025	11	4	13	2	15	25.2	-2.5	1.038	0.4	0.3	0	38.7	27.5	0	124	98	0	34	34	34
2025	11	4	13	12	15	24.8	-2.7	1.038	0.5	0.5	0	38.7	27.5	0	124	97	0	34	33	35
2025	11	4	13	22	15	24.8	-2.4	1.037	0.3	0.2	0	38.3	27.5	0	124	97	0	35	33	35
2025	11	4	13	32	15	24.1	-2.2	1.038	0.5	0.4	0	38.7	27.1	0	124	97	0	34	34	35
2025	11	4	13	42	15	24	-3.6	1.038	0.3	0.2	0	38.3	27.1	0	124	97	0	35	34	35
2025	11	4	13	52	15	24.9	-1.7	1.038	0.5	0.4	0	38.3	27.1	0	124	97	0	35	34	34
2025	11	4	14	2	15	23.9	-3.3	1.038	0.4	0.3	0	38.3	27.5	0	124	97	0	35	33	34
2025	11	4	14	12	15	24.1	-2.4	1.038	0.4	0.3	0	38.3	27.1	0	124	97	0	35	34	35
2025	11	4	14	22	15	25.6	-2.1	1.038	0.4	0.3	0	37.8	27.1	0	123	97	0	35	34	35
2025	11	4	14	32	15	23.8	-2.2	1.038	0.4	0.3	0	38.3	27.5	0	124	98	0	35	34	34
2025	11	4	14	42	15	23.6	-2.7	1.038	0.5	0.5	0	38.3	27.5	0	124	98	0	35	34	34
2025	11	4	14	52	15	24.4	-1.5	1.037	0.4	0.3	0	37.8	27.1	0	123	97	0	35	34	34
2025	11	4	15	2	15	24	-2.9	1.037	0.5	0.5	0	37.8	27.1	0	123	97	0	35	34	34
2025	11	4	15	12	15	24.8	-1.6	1.037	0.5	0.4	0	38.3	27.5	0	124	98	0	35	34	35
2025	11	4	15	22	15	24.2	-2.5	1.037	0.5	0.5	0	39.1	28	0	125	99	0	34	34	35
2025	11	4	15	32	15	23.6	-2.4	1.037	0.4	0.3	0	38.3	28	0	124	98	0	35	33	34
2025	11	4	15	42	15	24.6	-2.4	1.036	0.4	0.3	0	38.7	28	0	124	98	0	34	33	35
2025	11	4	15	52	15	24.4	-1.9	1.036	0.3	0.2	0	38.3	27.5	0	124	98	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	4	16	2	15	24.2	-2.3	1.037	0.5	0.4	0	38.3	28	0	124	98	0	35	33	34
2025	11	4	16	12	15	23.6	-3.2	1.036	0.5	0.4	0	38.7	28	0	125	98	0	35	33	34
2025	11	4	16	22	15	24.9	-2.5	1.036	0.5	0.4	0	38.3	27.1	0	124	97	0	35	34	35
2025	11	4	16	32	15	23.8	-3.2	1.036	0.4	0.3	0	37.8	26.7	0	123	96	0	35	34	34
2025	11	4	16	42	15	24.3	-2.9	1.037	0.5	0.4	0	38.3	27.5	0	123	97	0	34	33	35
2025	11	4	16	52	15	25.4	-2.1	1.037	0.4	0.3	0	38.7	27.5	0	124	97	0	34	33	35
2025	11	4	17	2	15	25.7	-2.2	1.037	0.4	0.3	0	38.3	27.5	0	124	97	0	35	33	34
2025	11	4	17	12	15	26.1	-3.3	1.037	0.3	0.2	0	38.3	27.1	0	124	97	0	35	34	34
2025	11	4	17	22	15	25.5	-2	1.037	0.3	0.2	0	38.3	27.1	0	123	96	0	34	33	34
2025	11	4	17	32	15	24.2	-2.5	1.037	0.5	0.4	0	38.3	27.1	0	124	97	0	35	34	35
2025	11	4	17	42	15	25.3	-3.4	1.037	0.4	0.3	0	38.3	27.1	0	124	97	0	35	34	34
2025	11	4	17	52	15	24.4	-3.4	1.037	0.5	0.4	0	38.7	27.1	0	124	97	0	34	34	34
2025	11	4	18	2	15	24.8	-2.9	1.037	0.5	0.4	0	39.6	28.8	0	127	100	0	35	33	34
2025	11	4	18	12	15	25.2	-3.5	1.037	0.4	0.3	0	39.6	28	0	127	99	0	35	34	35
2025	11	4	18	22	15	25.7	-3.4	1.037	0.3	0.2	0	39.6	28	0	126	98	0	34	33	34
2025	11	4	18	32	15	24.5	-2.8	1.037	0.3	0.2	0	40	28.8	0	127	100	0	34	33	34
2025	11	4	18	42	15	24.3	-2.3	1.037	0.5	0.4	0	40.4	29.2	0	129	101	0	35	33	34
2025	11	4	18	52	15	26	-3	1.037	0.5	0.4	0	40	28.8	0	128	101	0	35	34	34
2025	11	4	19	2	15	25.3	-3.4	1.037	0.3	0.2	0	40.9	30.1	0	130	103	0	35	33	35
2025	11	4	19	12	15	26.1	-3.8	1.037	0.5	0.4	0	40.4	29.2	0	129	102	0	35	34	35
2025	11	4	19	22	15	25.9	-2.7	1.037	0.5	0.5	0	40.4	29.2	0	129	102	0	35	34	35
2025	11	4	19	32	15	25.9	-3	1.037	0.4	0.3	0	40.4	29.7	0	129	103	0	35	34	35
2025	11	4	19	42	15	25.4	-3	1.037	0.4	0.3	0	40.9	30.1	0	130	103	0	35	33	35
2025	11	4	19	52	15	24.7	-3.2	1.037	0.4	0.3	0	40.4	29.7	0	129	103	0	35	34	34
2025	11	4	20	2	15	25.2	-3	1.037	0.4	0.3	0	40.9	29.7	0	130	103	0	35	34	34
2025	11	4	20	12	15	26.3	-3	1.037	0.5	0.4	0	41.3	31	0	131	105	0	35	33	34
2025	11	4	20	22	15	26.3	-3.5	1.037	0.4	0.3	0	41.3	30.1	0	131	104	0	35	34	34
2025	11	4	20	32	15	25.4	-3.5	1.037	0.4	0.3	0	41.7	30.1	0	131	104	0	34	34	35
2025	11	4	20	42	15	24.2	-2.8	1.036	0.5	0.4	0	41.3	30.1	0	131	104	0	35	34	35
2025	11	4	20	52	15	25.2	-3	1.037	0.4	0.3	0	41.3	30.1	0	131	104	0	35	34	35
2025	11	4	21	2	15	25.9	-2.5	1.037	0.3	0.2	0	40.9	30.1	0	130	104	0	35	34	35
2025	11	4	21	12	15	25.1	-2.9	1.037	0.5	0.4	0	41.3	30.5	0	131	104	0	35	33	34
2025	11	4	21	22	15	24.5	-3.3	1.037	0.5	0.4	0	41.3	30.1	0	131	104	0	35	34	34
2025	11	4	21	32	15	24.1	-2.9	1.037	0.5	0.5	0	40.9	30.1	0	130	104	0	35	34	34
2025	11	4	21	42	15	25	-3.9	1.037	0.5	0.4	0	41.3	30.1	0	131	104	0	35	34	34
2025	11	4	21	52	15	25	-2.9	1.037	0.4	0.3	0	41.3	30.1	0	131	104	0	35	34	34
2025	11	4	22	2	15	26.6	-2.9	1.036	0.4	0.3	0	41.3	30.1	0	131	104	0	35	34	35
2025	11	4	22	12	15	25.4	-2.5	1.036	0.5	0.5	0	41.3	30.1	0	131	104	0	35	34	34
2025	11	4	22	22	15	25	-3.3	1.036	0.5	0.4	0	41.3	30.1	0	131	104	0	35	34	34
2025	11	4	22	32	15	25.8	-2.5	1.037	0.5	0.4	0	41.3	30.1	0	131	104	0	35	34	35
2025	11	4	22	42	15	25.4	-2.7	1.036	0.5	0.4	0	41.7	30.5	0	132	104	0	35	33	35
2025	11	4	22	52	15	26.4	-3.9	1.036	0.5	0.4	0	42.1	30.1	0	132	104	0	34	34	35
2025	11	4	23	2	15	25.8	-3.1	1.037	0.5	0.4	0	41.3	30.1	0	131	103	0	35	33	34
2025	11	4	23	12	15	24.5	-3.1	1.036	0.5	0.4	0	41.7	29.7	0	131	103	0	34	34	35
2025	11	4	23	22	15	24.6	-3.1	1.036	0.4	0.3	0	41.7	30.1	0	132	104	0	35	34	35
2025	11	4	23	32	15	24	-2.8	1.036	0.4	0.3	0	42.1	30.1	0	132	104	0	34	34	35
2025	11	4	23	42	15	24.7	-2.5	1.036	0.5	0.4	0	41.3	29.7	0	131	103	0	35	34	35
2025	11	4	23	52	15	26.1	-2.3	1.036	0.3	0.2	0	41.7	30.1	0	132	104	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	5	0	2	15	25.6	-2.9	1.036	0.4	0.3	0	41.3	29.7	0	131	103	0	35	34	35
2025	11	5	0	12	15	24.9	-2.8	1.036	0.4	0.3	0	41.7	30.5	0	132	104	0	35	33	35
2025	11	5	0	22	15	24.9	-2.7	1.036	0.4	0.3	0	41.7	30.1	0	132	104	0	35	34	35
2025	11	5	0	32	15	25.9	-2.5	1.036	0.4	0.3	0	40.9	30.1	0	131	104	0	36	34	34
2025	11	5	0	42	15	24.9	-2.8	1.036	0.5	0.5	0	41.3	30.5	0	131	104	0	35	33	35
2025	11	5	0	52	15	24.4	-2.9	1.036	0.5	0.4	0	41.3	29.7	0	131	103	0	35	34	35
2025	11	5	1	2	15	24.9	-2.9	1.036	0.5	0.5	0	41.3	30.1	0	131	104	0	35	34	34
2025	11	5	1	12	15	26.5	-3.2	1.037	0.3	0.2	0	41.3	29.7	0	131	103	0	35	34	34
2025	11	5	1	22	15	25.4	-2.3	1.036	0.5	0.4	0	41.3	29.7	0	131	103	0	35	34	35
2025	11	5	1	32	15	23.8	-2.6	1.036	0.4	0.3	0	40.9	29.7	0	130	103	0	35	34	35
2025	11	5	1	42	15	26.4	-4.1	1.036	0.4	0.3	0	40.9	29.7	0	130	103	0	35	34	35
2025	11	5	1	52	15	25.6	-3.1	1.037	0.3	0.2	0	41.3	30.1	0	131	104	0	35	34	35
2025	11	5	2	2	15	26	-2.7	1.037	0.3	0.2	0	40.9	29.7	0	130	103	0	35	34	34
2025	11	5	2	12	15	26.5	-2.5	1.036	0.4	0.3	0	41.3	29.7	0	130	103	0	34	34	35
2025	11	5	2	22	15	24.9	-2.2	1.037	0.5	0.4	0	41.3	30.1	0	131	104	0	35	34	35
2025	11	5	2	32	15	24.2	-3.2	1.037	0.5	0.4	0	41.7	30.1	0	132	104	0	35	34	35
2025	11	5	2	42	15	25.8	-3.3	1.037	0.3	0.2	0	41.3	29.7	0	131	103	0	35	34	35
2025	11	5	2	52	15	25.3	-2.8	1.036	0.3	0.2	0	40.9	29.7	0	130	103	0	35	34	35
2025	11	5	3	2	15	24.4	-2.1	1.037	0.5	0.5	0	41.3	29.2	0	131	103	0	35	35	35
2025	11	5	3	12	15	24.6	-2.5	1.036	0.4	0.3	0	41.3	30.1	0	131	104	0	35	34	34
2025	11	5	3	22	15	25.1	-2.6	1.036	0.5	0.4	0	41.7	29.7	0	131	103	0	34	34	35
2025	11	5	3	32	15	25.3	-3.5	1.036	0.5	0.4	0	41.3	30.1	0	131	103	0	35	33	34
2025	11	5	3	42	15	24.2	-2.2	1.037	0.5	0.4	0	41.3	29.7	0	131	103	0	35	34	34
2025	11	5	3	52	15	24.7	-3.7	1.037	0.5	0.4	0	41.3	29.2	0	130	102	0	34	34	34
2025	11	5	4	2	15	24.9	-3.4	1.037	0.4	0.3	0	40.9	29.2	0	130	102	0	35	34	35
2025	11	5	4	12	15	25.6	-2.8	1.037	0.4	0.3	0	41.3	29.7	0	131	103	0	35	34	35
2025	11	5	4	22	15	24.3	-2.3	1.037	0.4	0.3	0	41.3	29.7	0	131	103	0	35	34	35
2025	11	5	4	32	15	25.3	-2.8	1.037	0.4	0.3	0	40.4	29.7	0	130	102	0	36	33	34
2025	11	5	4	42	15	25.1	-3.3	1.037	0.5	0.4	0	40.9	29.2	0	130	102	0	35	34	34
2025	11	5	4	52	15	24.6	-2.3	1.037	0.3	0.2	0	40.9	29.7	0	130	103	0	35	34	34
2025	11	5	5	2	15	24.1	-2.5	1.037	0.4	0.3	0	41.3	29.7	0	131	103	0	35	34	35
2025	11	5	5	12	15	25.2	-2.1	1.037	0.5	0.4	0	41.7	30.5	0	132	104	0	35	33	35
2025	11	5	5	22	15	25.8	-3.6	1.037	0.3	0.2	0	40.9	29.2	0	130	102	0	35	34	35
2025	11	5	5	32	15	25.2	-3.3	1.037	0.4	0.3	0	40.9	29.7	0	130	102	0	35	33	35
2025	11	5	5	42	15	24.6	-2.9	1.037	0.4	0.3	0	41.3	29.7	0	131	103	0	35	34	34
2025	11	5	5	52	15	25.8	-3.3	1.037	0.4	0.3	0	40.9	29.2	0	130	102	0	35	34	35
2025	11	5	6	2	15	24.6	-3	1.037	0.3	0.2	0	40.4	29.2	0	130	102	0	36	34	34
2025	11	5	6	12	15	24.8	-2.9	1.037	0.4	0.3	0	40.9	29.7	0	130	103	0	35	34	34
2025	11	5	6	22	15	25	-2.9	1.037	0.5	0.4	0	40.9	29.2	0	130	102	0	35	34	35
2025	11	5	6	32	15	25.5	-3.3	1.037	0.4	0.3	0	40.9	29.7	0	130	102	0	35	33	34
2025	11	5	6	42	15	25.3	-3.6	1.037	0.3	0.2	0	40.4	28.8	0	129	101	0	35	34	34
2025	11	5	6	52	15	25.4	-2.4	1.037	0.4	0.3	0	40.4	28.8	0	129	101	0	35	34	34
2025	11	5	7	2	15	25.3	-2.1	1.037	0.4	0.3	0	40	28.4	0	128	100	0	35	34	35
2025	11	5	7	12	15	24.9	-2.4	1.037	0.4	0.3	0	40.4	28.4	0	128	100	0	34	34	35
2025	11	5	7	22	15	24.8	-2.3	1.037	0.4	0.3	0	39.6	28.4	0	127	100	0	35	34	34
2025	11	5	7	32	15	26.2	-2.1	1.037	0.4	0.3	0	39.6	28.4	0	127	100	0	35	34	35
2025	11	5	7	42	15	24.2	-2.9	1.037	0.4	0.3	0	39.1	28.4	0	127	100	0	36	34	35
2025	11	5	7	52	15	24.6	-3	1.037	0.3	0.2	0	39.6	28.4	0	127	100	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	5	8	2	15	24.8	-3.4	1.037	0.3	0.2	0	39.6	28	0	127	99	0	35	34	35
2025	11	5	8	12	15	24.1	-2.9	1.037	0.4	0.3	0	39.1	28	0	126	99	0	35	34	35
2025	11	5	8	22	15	24.7	-3.5	1.037	0.3	0.2	0	39.1	28	0	126	99	0	35	34	34
2025	11	5	8	32	15	25.1	-2.5	1.037	0.4	0.3	0	39.6	28	0	126	99	0	34	34	34
2025	11	5	8	42	15	25.2	-3.5	1.037	0.4	0.3	0	39.1	28	0	126	99	0	35	34	35
2025	11	5	8	52	15	25.4	-2.5	1.037	0.3	0.2	0	39.6	28	0	126	99	0	34	34	34
2025	11	5	9	2	15	25.4	-2.4	1.038	0.4	0.3	0	38.7	28.4	0	125	99	0	35	33	35
2025	11	5	9	12	15	26.3	-3.7	1.038	0.4	0.3	0	38.7	28	0	125	98	0	35	33	35
2025	11	5	9	22	15	26	-3.5	1.038	0.3	0.2	0	38.7	27.5	0	125	98	0	35	34	35
2025	11	5	9	32	15	25.1	-2.9	1.038	0.3	0.2	0	38.7	27.1	0	124	97	0	34	34	35
2025	11	5	9	42	15	27	-3.7	1.038	0.4	0.3	0	38.7	27.1	0	124	96	0	34	33	34
2025	11	5	9	52	15	25.5	-4.1	1.038	0.5	0.4	0	37.8	26.7	0	123	96	0	35	34	34
2025	11	5	10	2	15	24.7	-3.2	1.038	0.5	0.5	0	37.8	26.7	0	123	96	0	35	34	34
2025	11	5	10	12	15	25.6	-3.7	1.038	0.5	0.5	0	37.8	26.7	0	123	95	0	35	33	34
2025	11	5	10	22	15	24.8	-3.1	1.038	0.3	0.2	0	37.4	26.2	0	122	94	0	35	33	35
2025	11	5	10	32	15	24.8	-3.3	1.038	0.3	0.2	0	37.4	25.8	0	121	94	0	34	34	35
2025	11	5	10	42	15	25.6	-2.2	1.038	0.4	0.3	0	37.4	25.8	0	122	94	0	35	34	34
2025	11	5	10	52	15	26.4	-2.9	1.038	0.4	0.3	0	37.8	26.2	0	123	95	0	35	34	34
2025	11	5	11	2	15	24.7	-2	1.037	0.3	0.2	0	37.8	27.1	0	123	97	0	35	34	34
2025	11	5	11	12	15	24.4	-1.7	1.037	0.3	0.2	0	38.3	27.5	0	124	98	0	35	34	34
2025	11	5	11	22	15	24.1	-1.9	1.037	0.3	0.2	0	37.8	27.1	0	123	97	0	35	34	34
2025	11	5	11	32	15	24.3	-1.2	1.036	0.4	0.3	0	38.3	28	0	124	98	0	35	33	35
2025	11	5	11	42	15	24.8	-2.1	1.037	0.4	0.3	0	38.7	28	0	125	99	0	35	34	35
2025	11	5	11	52	15	24.4	-2.6	1.036	0.4	0.3	0	39.6	28.8	0	127	100	0	35	33	35
2025	11	5	12	2	15	25.7	-1.9	1.037	0.3	0.2	0	39.6	28	0	126	99	0	34	34	35
2025	11	5	12	12	15	23.9	-2.5	1.037	0.3	0.2	0	40	28.8	0	127	100	0	34	33	35
2025	11	5	12	22	15	24.4	-2.6	1.037	0.5	0.5	0	39.6	28.8	0	127	100	0	35	33	34
2025	11	5	12	32	15	25.2	-3.4	1.036	0.4	0.3	0	40.9	29.2	0	129	102	0	34	34	34
2025	11	5	12	42	15	25.2	-3.1	1.035	0.3	0.2	0	40.9	29.2	0	129	102	0	34	34	34
2025	11	5	12	52	15	24.3	-2.7	1.036	0.4	0.3	0	40.4	29.7	0	129	103	0	35	34	35
2025	11	5	13	2	15	24	-2.3	1.036	0.5	0.4	0	41.3	30.5	0	131	105	0	35	34	34
2025	11	5	13	12	15	24.4	-1.8	1.037	0.3	0.2	0	41.3	30.1	0	131	104	0	35	34	34
2025	11	5	13	22	15	24	-2.6	1.036	0.4	0.3	0	41.7	30.5	0	132	105	0	35	34	34
2025	11	5	13	32	15	24.4	-3.1	1.037	0.5	0.4	0	41.7	31	0	132	105	0	35	33	34
2025	11	5	13	42	15	24.9	-2.5	1.037	0.5	0.4	0	41.7	30.1	0	131	104	0	34	34	34
2025	11	5	13	52	15	24	-1.7	1.036	0.5	0.4	0	41.7	30.5	0	131	105	0	34	34	34
2025	11	5	14	2	15	23.7	-2.5	1.035	0.5	0.4	0	41.3	30.5	0	131	105	0	35	34	34
2025	11	5	14	12	15	23.6	-3.2	1.035	0.5	0.4	0	41.3	31	0	131	105	0	35	33	35
2025	11	5	14	22	15	23.8	-3	1.036	0.3	0.2	0	41.3	30.5	0	131	105	0	35	34	34
2025	11	5	14	32	15	24.1	-2.7	1.036	0.3	0.2	0	41.3	30.5	0	131	105	0	35	34	35
2025	11	5	14	42	15	24.5	-3	1.036	0.3	0.2	0	40.9	30.1	0	130	104	0	35	34	34
2025	11	5	14	52	15	24.5	-2.7	1.035	0.5	0.4	0	40.4	30.5	0	129	104	0	35	33	35
2025	11	5	15	2	15	24.8	-1.9	1.036	0.4	0.3	0	40.4	29.7	0	129	103	0	35	34	35
2025	11	5	15	12	15	24.5	-3	1.035	0.5	0.4	0	40	29.7	0	128	102	0	35	33	34
2025	11	5	15	22	15	25.7	-1.7	1.036	0.4	0.3	0	39.6	28.8	0	127	100	0	35	33	34
2025	11	5	15	32	15	24.8	-2.4	1.035	0.3	0.2	0	39.6	29.2	0	127	101	0	35	33	34
2025	11	5	15	42	15	23.6	-3.2	1.036	0.4	0.3	0	39.6	29.7	0	127	102	0	35	33	34
2025	11	5	15	52	15	24.2	-2.5	1.036	0.4	0.3	0	38.7	28.4	0	125	99	0	35	33	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	5	16	2	15	24	-1.7	1.035	0.5	0.4	0	38.7	28	0	125	98	0	35	33	34
2025	11	5	16	12	15	23.4	-2.1	1.035	0.4	0.3	0	39.1	27.1	0	125	97	0	34	34	34
2025	11	5	16	22	15	25.3	-3.7	1.035	0.4	0.3	0	38.7	27.5	0	124	97	0	34	33	34
2025	11	5	16	32	15	23.7	-1.8	1.034	0.3	0.2	0	38.3	27.5	0	124	97	0	35	33	35
2025	11	5	16	42	15	24.8	-3	1.034	0.3	0.2	0	38.3	27.5	0	123	97	0	34	33	35
2025	11	5	16	52	15	24.5	-2.2	1.035	0.4	0.3	0	37.8	27.1	0	123	97	0	35	34	34
2025	11	5	17	2	15	23.8	-2.7	1.034	0.5	0.4	0	37.8	27.1	0	123	96	0	35	33	35
2025	11	5	17	12	15	24.4	-2.2	1.034	0.4	0.3	0	37.8	27.1	0	123	96	0	35	33	35
2025	11	5	17	22	15	23.6	-2.1	1.035	0.5	0.5	0	38.3	27.1	0	124	97	0	35	34	34
2025	11	5	17	32	15	24.8	-1.7	1.034	0.4	0.3	0	39.1	28	0	125	98	0	34	33	34
2025	11	5	17	42	15	24.5	-2.5	1.035	0.5	0.4	0	38.3	27.5	0	124	97	0	35	33	34
2025	11	5	17	52	15	26	-3.8	1.035	0.4	0.3	0	38.7	27.5	0	125	97	0	35	33	35
2025	11	5	18	2	15	24.8	-1.9	1.033	0.4	0.3	0	38.7	27.1	0	124	97	0	34	34	34
2025	11	5	18	12	15	24	-1.5	1.034	0.5	0.4	0	38.7	27.1	0	125	97	0	35	34	35
2025	11	5	18	22	15	24.8	-2.3	1.033	0.3	0.2	0	38.7	27.5	0	125	97	0	35	33	34
2025	11	5	18	32	15	24.2	-1.8	1.033	0.5	0.4	0	38.7	28.4	0	125	98	0	35	32	34
2025	11	5	18	42	15	23.8	-1.4	1.033	0.4	0.3	0	39.6	28	0	126	99	0	34	34	34
2025	11	5	18	52	15	24.5	-2.6	1.033	0.5	0.5	0	39.6	28	0	126	99	0	34	34	34
2025	11	5	19	2	15	24.8	-3	1.033	0.5	0.4	0	39.6	28	0	127	99	0	35	34	34
2025	11	5	19	12	15	24.4	-2.1	1.033	0.3	0.2	0	39.6	28.4	0	126	99	0	34	33	34
2025	11	5	19	22	15	23.9	-1.9	1.033	0.4	0.3	0	39.1	28	0	126	99	0	35	34	34
2025	11	5	19	32	15	23.5	-2.6	1.033	0.5	0.4	0	39.6	28	0	127	99	0	35	34	35
2025	11	5	19	42	15	24.1	-1.9	1.033	0.4	0.3	0	39.1	28.4	0	126	99	0	35	33	35
2025	11	5	19	52	15	23.9	-3.1	1.033	0.5	0.4	0	39.1	28	0	126	99	0	35	34	34
2025	11	5	20	2	15	23.5	-1.7	1.034	0.4	0.3	0	40	28	0	127	99	0	34	34	34
2025	11	5	20	12	15	24.7	-1.5	1.034	0.5	0.4	0	39.1	28	0	126	99	0	35	34	34
2025	11	5	20	22	15	24.3	-1.7	1.035	0.4	0.3	0	39.1	28	0	126	98	0	35	33	34
2025	11	5	20	32	15	23.9	-3.1	1.035	0.4	0.3	0	39.6	28.4	0	127	99	0	35	33	35
2025	11	5	20	42	15	24.8	-2.4	1.035	0.5	0.4	0	39.1	28	0	126	99	0	35	34	35
2025	11	5	20	52	15	24.3	-3	1.034	0.5	0.5	0	39.1	27.5	0	126	98	0	35	34	34
2025	11	5	21	2	15	25.7	-2.7	1.034	0.3	0.2	0	38.7	27.5	0	125	98	0	35	34	34
2025	11	5	21	12	15	24.4	-3.1	1.033	0.3	0.2	0	39.6	28.4	0	126	99	0	34	33	34
2025	11	5	21	22	15	26.1	-2.8	1.034	0.5	0.4	0	38.7	28	0	125	99	0	35	34	34
2025	11	5	21	32	15	23.7	-3.1	1.035	0.5	0.4	0	39.1	28.4	0	126	98	0	35	32	34
2025	11	5	21	42	15	25.5	-2.6	1.034	0.6	0.5	0	38.7	27.1	0	125	97	0	35	34	35
2025	11	5	21	52	15	24.7	-2.6	1.034	0.3	0.2	0	38.7	28	0	125	98	0	35	33	34
2025	11	5	22	2	15	25.1	-3.4	1.034	0.5	0.4	0	39.1	27.5	0	125	98	0	34	34	35
2025	11	5	22	12	15	24.7	-2.8	1.034	0.5	0.4	0	38.7	27.5	0	125	98	0	35	34	34
2025	11	5	22	22	15	24.1	-1.9	1.034	0.3	0.2	0	38.7	27.5	0	125	98	0	35	34	35
2025	11	5	22	32	15	24.7	-2.3	1.034	0.5	0.4	0	39.1	27.5	0	125	98	0	34	34	34
2025	11	5	22	42	15	23.9	-2.5	1.034	0.4	0.3	0	38.7	27.5	0	125	98	0	35	34	35
2025	11	5	22	52	15	25.4	-2.4	1.034	0.3	0.2	0	38.7	27.5	0	125	98	0	35	34	34
2025	11	5	23	2	15	24.6	-2.2	1.034	0.3	0.2	0	38.7	28	0	125	98	0	35	33	35
2025	11	5	23	12	15	23.8	-2.5	1.034	0.4	0.3	0	38.7	27.5	0	125	98	0	35	34	35
2025	11	5	23	22	15	25.3	-2.1	1.036	0.4	0.3	0	38.7	27.5	0	125	98	0	35	34	34
2025	11	5	23	32	15	25	-2.1	1.036	0.3	0.2	0	39.1	27.5	0	126	98	0	35	34	35
2025	11	5	23	42	15	24.5	-2.6	1.037	0.5	0.4	0	39.6	28.4	0	126	99	0	34	33	34
2025	11	5	23	52	15	22.4	-2.3	1.036	0.3	0.2	0	39.6	28.4	0	127	100	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	6	0	2	15	24.5	-1.8	1.037	0.4	0.3	0	39.6	28	0	127	99	0	35	34	34
2025	11	6	0	12	15	24.6	-3.5	1.036	0.5	0.4	0	39.6	28	0	127	99	0	35	34	34
2025	11	6	0	22	15	24.6	-2.1	1.037	0.3	0.2	0	39.1	28.4	0	126	99	0	35	33	35
2025	11	6	0	32	15	24.6	-3.3	1.037	0.3	0.2	0	38.7	27.5	0	125	98	0	35	34	35
2025	11	6	0	42	15	24.1	-2.4	1.037	0.4	0.3	0	39.1	28	0	126	98	0	35	33	34
2025	11	6	0	52	15	25.2	-2.7	1.037	0.4	0.3	0	38.7	27.5	0	125	98	0	35	34	34
2025	11	6	1	2	15	24.9	-2.9	1.037	0.4	0.3	0	39.1	27.5	0	126	98	0	35	34	34
2025	11	6	1	12	15	24.7	-1.9	1.037	0.5	0.4	0	39.1	27.5	0	126	98	0	35	34	34
2025	11	6	1	22	15	24	-2.3	1.037	0.4	0.3	0	39.1	28	0	126	98	0	35	33	34
2025	11	6	1	32	15	24.7	-3.3	1.037	0.5	0.4	0	39.1	28	0	126	98	0	35	33	34
2025	11	6	1	42	15	23.8	-2.5	1.037	0.4	0.3	0	38.7	27.1	0	125	97	0	35	34	34
2025	11	6	1	52	15	25.3	-2.9	1.038	0.4	0.3	0	38.7	27.5	0	125	98	0	35	34	34
2025	11	6	2	2	15	25.2	-2.4	1.038	0.4	0.3	0	38.7	28	0	125	98	0	35	33	34
2025	11	6	2	12	15	23.8	-2.2	1.038	0.3	0.2	0	39.1	27.5	0	126	98	0	35	34	34
2025	11	6	2	22	15	24.6	-3	1.038	0.5	0.4	0	39.6	27.5	0	126	98	0	34	34	35
2025	11	6	2	32	15	24.6	-3	1.038	0.5	0.4	0	38.7	27.5	0	125	98	0	35	34	35
2025	11	6	2	42	15	23.8	-3.4	1.038	0.5	0.4	0	39.1	28	0	126	98	0	35	33	35
2025	11	6	2	52	15	24.7	-2.8	1.038	0.4	0.3	0	39.1	27.5	0	126	98	0	35	34	34
2025	11	6	3	2	15	24.7	-2.5	1.038	0.4	0.3	0	39.1	28	0	126	98	0	35	33	34
2025	11	6	3	12	15	25.6	-2.8	1.038	0.4	0.3	0	39.1	28	0	126	98	0	35	33	34
2025	11	6	3	22	15	25.4	-1.7	1.038	0.5	0.4	0	38.7	28	0	125	99	0	35	34	34
2025	11	6	3	32	15	24.5	-2.6	1.039	0.5	0.4	0	39.1	28	0	126	99	0	35	34	35
2025	11	6	3	42	15	25.3	-2.5	1.039	0.4	0.3	0	39.1	28	0	126	99	0	35	34	35
2025	11	6	3	52	15	25.5	-2.5	1.039	0.5	0.4	0	39.1	28	0	126	98	0	35	33	34
2025	11	6	4	2	15	24.1	-2.1	1.039	0.4	0.3	0	39.6	28	0	126	99	0	34	34	35
2025	11	6	4	12	15	24.5	-2.8	1.039	0.3	0.2	0	38.7	28.4	0	125	99	0	35	33	34
2025	11	6	4	22	15	24.1	-2.5	1.039	0.4	0.3	0	39.1	28	0	126	99	0	35	34	35
2025	11	6	4	32	15	23.5	-1.7	1.039	0.5	0.4	0	39.6	28.8	0	127	100	0	35	33	34
2025	11	6	4	42	15	25.3	-3.3	1.039	0.5	0.4	0	39.1	28	0	126	99	0	35	34	35
2025	11	6	4	52	15	23.9	-3	1.039	0.4	0.3	0	39.1	28.8	0	126	100	0	35	33	35
2025	11	6	5	2	15	25.3	-2.8	1.039	0.4	0.3	0	39.1	28.4	0	126	100	0	35	34	35
2025	11	6	5	12	15	26.2	-3.2	1.039	0.3	0.2	0	39.6	28.8	0	127	100	0	35	33	35
2025	11	6	5	22	15	23.5	-3.1	1.039	0.4	0.3	0	39.6	28	0	126	99	0	34	34	35
2025	11	6	5	32	15	24	-2.9	1.04	0.5	0.4	0	39.1	28	0	126	99	0	35	34	35
2025	11	6	5	42	15	25.5	-2.5	1.039	0.5	0.4	0	39.1	28.4	0	126	100	0	35	34	34
2025	11	6	5	52	15	26.4	-2.8	1.039	0.4	0.3	0	39.6	29.2	0	127	101	0	35	33	35
2025	11	6	6	2	15	24	-2.8	1.04	0.5	0.4	0	39.6	28.8	0	127	101	0	35	34	34
2025	11	6	6	12	15	24.1	-2.4	1.04	0.3	0.2	0	39.6	28.8	0	127	101	0	35	34	35
2025	11	6	6	22	15	24	-2.8	1.04	0.5	0.4	0	40.9	29.2	0	129	102	0	34	34	35
2025	11	6	6	32	15	24.7	-2.9	1.04	0.4	0.3	0	40	29.2	0	127	101	0	34	33	35
2025	11	6	6	42	15	24.7	-2.5	1.04	0.4	0.3	0	39.6	28.4	0	126	100	0	34	34	34
2025	11	6	6	52	15	25.4	-2.5	1.04	0.3	0.2	0	39.6	28.4	0	127	100	0	35	34	35
2025	11	6	7	2	15	23.9	-2.1	1.04	0.6	0.5	0	39.1	28.4	0	126	99	0	35	33	35
2025	11	6	7	12	15	23.8	-3.1	1.04	0.5	0.4	0	39.1	28	0	126	100	0	35	35	35
2025	11	6	7	22	15	24.7	-2.4	1.04	0.3	0.2	0	42.6	31.4	0	134	107	0	35	34	35
2025	11	6	7	32	15	26	-3.3	1.04	0.5	0.4	0	45.6	34.8	0	141	115	0	35	34	35
2025	11	6	7	42	15	24.4	-3.2	1.04	0.3	0.2	0	42.1	31.4	0	133	107	0	35	34	35
2025	11	6	7	52	15	24.4	-2.4	1.041	0.4	0.3	0	43.4	32.7	0	136	110	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	6	8	2	15	24.6	-3.3	1.041	0.4	0.3	0	41.3	30.1	0	131	104	0	35	34	35
2025	11	6	8	12	15	24.8	-3.1	1.041	0.4	0.3	0	39.6	28.8	0	127	100	0	35	33	35
2025	11	6	8	22	15	25.9	-2.1	1.041	0.3	0.2	0	39.6	28.4	0	126	100	0	34	34	35
2025	11	6	8	32	15	23.6	-2.9	1.041	0.4	0.3	0	38.7	28	0	125	99	0	35	34	34
2025	11	6	8	42	15	24.9	-2.9	1.041	0.5	0.4	0	38.7	28.4	0	125	100	0	35	34	35
2025	11	6	8	52	15	24.3	-3	1.041	0.4	0.3	0	39.1	28.4	0	126	100	0	35	34	34
2025	11	6	9	2	15	24.7	-2.5	1.041	0.4	0.3	0	39.1	27.5	0	125	98	0	34	34	34
2025	11	6	9	12	15	26.1	-3.1	1.041	0.4	0.3	0	38.7	27.5	0	124	98	0	34	34	34
2025	11	6	9	22	15	24.4	-2.5	1.041	0.5	0.4	0	38.7	27.5	0	124	98	0	34	34	35
2025	11	6	9	32	15	25.2	-2.3	1.042	0.4	0.3	0	38.7	27.5	0	124	98	0	34	34	34
2025	11	6	9	42	15	24.4	-3	1.042	0.5	0.5	0	37.8	27.5	0	123	97	0	35	33	35
2025	11	6	9	52	15	25.3	-2.6	1.042	0.4	0.3	0	37.8	27.5	0	123	97	0	35	33	34
2025	11	6	10	2	15	24.9	-3	1.042	0.3	0.2	0	37.4	26.7	0	122	96	0	35	34	34
2025	11	6	10	12	15	24.8	-2.2	1.042	0.3	0.2	0	37.4	26.7	0	122	96	0	35	34	35
2025	11	6	10	22	15	24	-2.5	1.042	0.4	0.3	0	37.8	26.7	0	123	96	0	35	34	34
2025	11	6	10	32	15	23.8	-2.2	1.043	0.5	0.5	0	38.3	27.5	0	123	97	0	34	33	35
2025	11	6	10	42	15	24	-3	1.043	0.3	0.2	0	37.8	27.1	0	123	97	0	35	34	34
2025	11	6	10	52	15	25.1	-3.4	1.043	0.5	0.4	0	37.4	27.1	0	122	97	0	35	34	35
2025	11	6	11	2	15	25.3	-1.9	1.043	0.3	0.2	0	38.3	27.1	0	123	97	0	34	34	34
2025	11	6	11	12	15	24.5	-3.3	1.043	0.3	0.2	0	37.4	27.1	0	122	97	0	35	34	35
2025	11	6	11	22	15	25.6	-2.7	1.043	0.4	0.3	0	37.4	26.7	0	122	96	0	35	34	34
2025	11	6	11	32	15	23.6	-1.3	1.043	0.5	0.4	0	37.8	27.1	0	122	97	0	34	34	34
2025	11	6	11	42	15	25.4	-1.2	1.043	0.5	0.5	0	37.4	27.1	0	122	96	0	35	33	34
2025	11	6	11	52	15	24.7	-2.5	1.043	0.4	0.3	0	38.3	27.5	0	124	97	0	35	33	34
2025	11	6	12	2	15	23.6	-3.5	1.043	0.4	0.3	0	38.7	28	0	124	98	0	34	33	34
2025	11	6	12	12	15	23.2	-2.5	1.043	0.3	0.2	0	37.8	27.1	0	123	97	0	35	34	35
2025	11	6	12	22	15	23.8	-1.7	1.044	0.5	0.4	0	37.4	27.1	0	122	97	0	35	34	34
2025	11	6	12	32	15	24.1	-1.6	1.044	0.3	0.2	0	37.4	26.7	0	122	96	0	35	34	34
2025	11	6	12	42	15	25.2	-3	1.043	0.4	0.3	0	37.8	27.1	0	122	96	0	34	33	34
2025	11	6	12	52	15	25	-1.9	1.044	0.4	0.3	0	37	27.1	0	121	96	0	35	33	33
2025	11	6	13	2	15	24.7	-3	1.044	0.4	0.3	0	37	26.2	0	121	95	0	35	34	35
2025	11	6	13	12	15	24.7	-2.1	1.044	0.3	0.2	0	37.4	26.7	0	122	96	0	35	34	34
2025	11	6	13	22	15	25.4	-3.6	1.044	0.4	0.3	0	37	26.7	0	121	95	0	35	33	34
2025	11	6	13	32	15	24.4	-2.3	1.044	0.3	0.2	0	37.4	26.2	0	121	95	0	34	34	34
2025	11	6	13	42	15	25.2	-3	1.044	0.5	0.4	0	37	26.7	0	121	95	0	35	33	34
2025	11	6	13	52	15	24.3	-1.6	1.044	0.5	0.4	0	37.4	26.2	0	121	95	0	34	34	35
2025	11	6	14	2	15	24.9	-1.8	1.044	0.5	0.4	0	37.4	26.7	0	121	95	0	34	33	34
2025	11	6	14	12	15	25.3	-2.7	1.044	0.4	0.3	0	37	26.7	0	121	95	0	35	33	34
2025	11	6	14	22	15	24.6	-2.6	1.044	0.3	0.2	0	37	26.7	0	121	95	0	35	33	34
2025	11	6	14	32	15	24.1	-3.1	1.044	0.5	0.4	0	37.4	27.1	0	122	96	0	35	33	34
2025	11	6	14	42	15	25.4	-2.1	1.044	0.4	0.3	0	37.4	26.7	0	122	96	0	35	34	34
2025	11	6	14	52	15	24.2	-3	1.044	0.5	0.4	0	37.4	26.7	0	122	96	0	35	34	34
2025	11	6	15	2	15	24.7	-1.8	1.044	0.3	0.2	0	37	26.7	0	121	96	0	35	34	35
2025	11	6	15	12	15	24.7	-2.8	1.044	0.3	0.2	0	37.4	26.7	0	121	96	0	34	34	34
2025	11	6	15	22	15	25.5	-1.8	1.044	0.5	0.4	0	37.4	26.7	0	121	96	0	34	34	34
2025	11	6	15	32	15	24.6	-2.6	1.044	0.4	0.3	0	37.4	26.7	0	122	96	0	35	34	35
2025	11	6	15	42	15	24.1	-3.1	1.044	0.5	0.5	0	37.8	27.5	0	123	97	0	35	33	35
2025	11	6	15	52	15	25.5	-2.5	1.044	0.3	0.2	0	37.4	27.5	0	122	97	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	6	16	2	15	25.4	-2.5	1.044	0.3	0.2	0	38.3	27.1	0	123	97	0	34	34	34
2025	11	6	16	12	15	24.4	-2.8	1.044	0.6	0.5	0	37.8	27.1	0	122	96	0	34	33	34
2025	11	6	16	22	15	25.2	-2.6	1.044	0.3	0.2	0	37.8	26.7	0	122	96	0	34	34	34
2025	11	6	16	32	15	23.2	-2.2	1.044	0.4	0.3	0	37.8	26.7	0	122	96	0	34	34	34
2025	11	6	16	42	15	25	-1.8	1.044	0.4	0.3	0	37.4	26.2	0	122	95	0	35	34	34
2025	11	6	16	52	15	24.5	-3.3	1.044	0.4	0.3	0	37	26.2	0	121	95	0	35	34	35
2025	11	6	17	2	15	24.6	-3	1.044	0.4	0.3	0	37.8	26.7	0	122	95	0	34	33	34
2025	11	6	17	12	15	24.6	-2.2	1.045	0.5	0.4	0	37.4	26.7	0	122	95	0	35	33	35
2025	11	6	17	22	15	24.6	-2.6	1.045	0.5	0.4	0	37.4	26.7	0	122	96	0	35	34	34
2025	11	6	17	32	15	24.2	-3	1.044	0.5	0.4	0	37.4	26.2	0	122	95	0	35	34	35
2025	11	6	17	42	15	25.3	-3.4	1.044	0.4	0.3	0	37	25.8	0	121	94	0	35	34	34
2025	11	6	17	52	15	24.7	-3.1	1.045	0.4	0.3	0	38.3	27.1	0	123	96	0	34	33	35
2025	11	6	18	2	15	25.1	-2.7	1.045	0.4	0.3	0	37.8	27.1	0	122	96	0	34	33	34
2025	11	6	18	12	15	25.3	-3.2	1.045	0.4	0.3	0	38.3	26.7	0	123	96	0	34	34	34
2025	11	6	18	22	15	24.5	-2	1.046	0.4	0.3	0	39.1	27.5	0	126	98	0	35	34	35
2025	11	6	18	32	15	24.9	-1.6	1.047	0.5	0.5	0	38.7	28	0	125	98	0	35	33	35
2025	11	6	18	42	15	23.5	-1.6	1.047	0.3	0.2	0	39.6	28.4	0	127	100	0	35	34	35
2025	11	6	18	52	15	25.3	-1.6	1.047	0.3	0.2	0	40	28.8	0	128	101	0	35	34	35
2025	11	6	19	2	15	24	-3.3	1.048	0.5	0.4	0	40	28.8	0	127	100	0	34	33	34
2025	11	6	19	12	15	24.5	-2.6	1.048	0.5	0.4	0	39.6	28.8	0	127	100	0	35	33	34
2025	11	6	19	22	15	25.3	-1.9	1.048	0.3	0.2	0	40.9	28.8	0	129	100	0	34	33	35
2025	11	6	19	32	15	24.9	-2.8	1.048	0.3	0.2	0	40.9	29.2	0	129	101	0	34	33	34
2025	11	6	19	42	15	24.6	-2.5	1.049	0.3	0.2	0	40.4	28.8	0	128	100	0	34	33	35
2025	11	6	19	52	15	26.2	-2.6	1.049	0.4	0.3	0	40.4	28.8	0	129	101	0	35	34	35
2025	11	6	20	2	15	25.5	-2.6	1.049	0.4	0.3	0	41.3	29.7	0	130	102	0	34	33	34
2025	11	6	20	12	15	25.1	-2.9	1.049	0.4	0.3	0	40.4	28.8	0	129	101	0	35	34	34
2025	11	6	20	22	15	25.5	-2.6	1.049	0.3	0.2	0	40.4	29.7	0	129	102	0	35	33	35
2025	11	6	20	32	15	25.5	-3.3	1.049	0.3	0.2	0	40.9	29.2	0	130	102	0	35	34	34
2025	11	6	20	42	15	25.5	-3.8	1.049	0.4	0.3	0	40.4	28.8	0	129	101	0	35	34	35
2025	11	6	20	52	15	25.4	-2.4	1.049	0.4	0.3	0	40.4	28.8	0	129	101	0	35	34	34
2025	11	6	21	2	15	25.4	-3.2	1.049	0.4	0.3	0	40	28.8	0	128	100	0	35	33	34
2025	11	6	21	12	15	25.6	-2.5	1.049	0.4	0.3	0	40.9	29.2	0	130	102	0	35	34	35
2025	11	6	21	22	15	24.7	-3	1.049	0.5	0.4	0	40.9	29.2	0	130	102	0	35	34	35
2025	11	6	21	32	15	25.2	-2.5	1.049	0.5	0.4	0	40.9	30.1	0	130	103	0	35	33	34
2025	11	6	21	42	15	26	-3.1	1.05	0.3	0.2	0	40.4	29.2	0	129	101	0	35	33	34
2025	11	6	21	52	15	26.9	-3.3	1.049	0.5	0.5	0	40.4	28.8	0	129	101	0	35	34	34
2025	11	6	22	2	15	24.8	-2.8	1.05	0.4	0.3	0	40.9	28.8	0	129	101	0	34	34	35
2025	11	6	22	12	15	24.4	-1.9	1.05	0.3	0.2	0	40.9	29.2	0	130	102	0	35	34	34
2025	11	6	22	22	15	25	-3.4	1.05	0.4	0.3	0	40.9	29.2	0	130	102	0	35	34	35
2025	11	6	22	32	15	26	-2.8	1.05	0.3	0.2	0	40.9	29.2	0	130	102	0	35	34	35
2025	11	6	22	42	15	25.6	-2.5	1.05	0.3	0.2	0	40.9	29.2	0	130	102	0	35	34	35
2025	11	6	22	52	15	24.1	-2.9	1.05	0.5	0.4	0	41.3	29.7	0	131	103	0	35	34	34
2025	11	6	23	2	15	25.3	-2.5	1.05	0.4	0.3	0	41.3	29.2	0	130	102	0	34	34	34
2025	11	6	23	12	15	24.4	-2.2	1.05	0.5	0.4	0	41.3	29.2	0	130	102	0	34	34	35
2025	11	6	23	22	15	25.9	-1.7	1.05	0.4	0.3	0	41.3	30.1	0	131	103	0	35	33	34
2025	11	6	23	32	15	25.1	-2.5	1.05	0.5	0.4	0	41.7	29.7	0	131	103	0	34	34	34
2025	11	6	23	42	15	25.7	-2.9	1.05	0.4	0.3	0	40.9	29.7	0	130	103	0	35	34	34
2025	11	6	23	52	15	26.2	-2.2	1.05	0.4	0.3	0	41.3	29.7	0	131	103	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	7	0	2	15	24.6	-2.1	1.05	0.4	0.3	0	41.3	29.7	0	131	103	0	35	34	35
2025	11	7	0	12	15	26.2	-2.4	1.05	0.5	0.4	0	40.9	29.2	0	130	102	0	35	34	35
2025	11	7	0	22	15	25.3	-1.8	1.05	0.4	0.3	0	40.9	29.2	0	130	102	0	35	34	35
2025	11	7	0	32	15	24.4	-2.9	1.05	0.4	0.3	0	40.9	29.7	0	130	102	0	35	33	35
2025	11	7	0	42	15	23.8	-1.6	1.05	0.4	0.3	0	40.9	29.7	0	130	103	0	35	34	35
2025	11	7	0	52	15	24.6	-3.5	1.05	0.5	0.4	0	41.3	29.7	0	131	103	0	35	34	34
2025	11	7	1	2	15	25.2	-2.9	1.05	0.4	0.3	0	41.3	29.7	0	130	103	0	34	34	34
2025	11	7	1	12	15	26.4	-2.1	1.05	0.4	0.3	0	40.4	29.2	0	129	102	0	35	34	35
2025	11	7	1	22	15	25	-2.5	1.05	0.3	0.2	0	41.3	29.7	0	131	103	0	35	34	34
2025	11	7	1	32	15	26.1	-3.3	1.051	0.5	0.4	0	40.9	29.7	0	130	102	0	35	33	34
2025	11	7	1	42	15	26.4	-3.3	1.05	0.4	0.3	0	40.9	29.2	0	130	102	0	35	34	35
2025	11	7	1	52	15	24.5	-2.9	1.05	0.4	0.3	0	42.1	30.5	0	133	105	0	35	34	34
2025	11	7	2	2	15	24.7	-2.5	1.05	0.5	0.4	0	41.3	29.7	0	131	103	0	35	34	35
2025	11	7	2	12	15	25.2	-2.9	1.051	0.4	0.3	0	40.9	29.2	0	130	102	0	35	34	34
2025	11	7	2	22	15	24.9	-2.1	1.051	0.5	0.4	0	41.7	29.7	0	131	103	0	34	34	34
2025	11	7	2	32	15	25.1	-2.9	1.051	0.3	0.2	0	40.4	29.2	0	129	101	0	35	33	35
2025	11	7	2	42	15	24.9	-2.2	1.051	0.3	0.2	0	41.3	29.2	0	130	102	0	34	34	34
2025	11	7	2	52	15	26	-2.4	1.051	0.5	0.4	0	42.1	30.5	0	133	104	0	35	33	35
2025	11	7	3	2	15	24.3	-2.3	1.051	0.4	0.3	0	41.3	29.7	0	131	103	0	35	34	34
2025	11	7	3	12	15	26	-2.9	1.051	0.3	0.2	0	43	31	0	135	106	0	35	34	35
2025	11	7	3	22	15	24.7	-2.9	1.051	0.3	0.2	0	42.1	30.1	0	132	103	0	34	33	35
2025	11	7	3	32	15	25.3	-3.6	1.051	0.3	0.2	0	40.9	29.2	0	130	102	0	35	34	34
2025	11	7	3	42	15	25.5	-2.8	1.051	0.4	0.3	0	41.3	29.7	0	131	102	0	35	33	35
2025	11	7	3	52	15	23.9	-2.4	1.051	0.4	0.3	0	40.9	29.2	0	130	102	0	35	34	34
2025	11	7	4	2	15	25.6	-2.3	1.051	0.5	0.4	0	41.3	29.7	0	130	102	0	34	33	35
2025	11	7	4	12	15	25.8	-3.1	1.051	0.3	0.2	0	40.9	28.8	0	130	101	0	35	34	34
2025	11	7	4	22	15	25.5	-1.6	1.051	0.4	0.3	0	40.9	29.2	0	130	102	0	35	34	35
2025	11	7	4	32	15	25.6	-2.6	1.052	0.4	0.3	0	40.4	28.4	0	129	100	0	35	34	34
2025	11	7	4	42	15	25.1	-2.5	1.051	0.5	0.5	0	41.3	28.8	0	130	101	0	34	34	34
2025	11	7	4	52	15	25.1	-2.9	1.051	0.5	0.4	0	40.9	28.4	0	129	100	0	34	34	34
2025	11	7	5	2	15	25.2	-2.5	1.052	0.3	0.2	0	40.4	28.8	0	129	101	0	35	34	34
2025	11	7	5	12	15	25.1	-2.8	1.051	0.4	0.3	0	40.4	28.8	0	129	100	0	35	33	35
2025	11	7	5	22	15	25.2	-2.4	1.052	0.3	0.2	0	40	28.4	0	128	100	0	35	34	35
2025	11	7	5	32	15	25	-2.9	1.052	0.4	0.3	0	40.4	29.2	0	129	101	0	35	33	35
2025	11	7	5	42	15	26	-1.9	1.052	0.4	0.3	0	40.4	28.8	0	128	101	0	34	34	35
2025	11	7	5	52	15	26	-3.2	1.052	0.4	0.3	0	40	28.8	0	128	100	0	35	33	34
2025	11	7	6	2	15	25.1	-2.1	1.052	0.4	0.3	0	40.4	28.8	0	129	101	0	35	34	34
2025	11	7	6	12	15	25.7	-2.7	1.052	0.3	0.2	0	40	28.8	0	128	100	0	35	33	35
2025	11	7	6	22	15	25.3	-2.6	1.052	0.4	0.3	0	40	28.4	0	128	100	0	35	34	35
2025	11	7	6	32	15	24.9	-2.1	1.052	0.4	0.3	0	40	28.4	0	128	100	0	35	34	34
2025	11	7	6	42	15	25.2	-4.2	1.052	0.4	0.3	0	40	28	0	128	99	0	35	34	34
2025	11	7	6	52	15	26.1	-3.6	1.053	0.4	0.3	0	39.6	28	0	127	99	0	35	34	34
2025	11	7	7	2	15	25.9	-3	1.053	0.4	0.3	0	39.6	28	0	127	99	0	35	34	34
2025	11	7	7	12	15	26	-3	1.053	0.3	0.2	0	39.1	28	0	126	99	0	35	34	35
2025	11	7	7	22	15	24.4	-3.2	1.053	0.4	0.3	0	43.4	32.3	0	136	108	0	35	33	35
2025	11	7	7	32	15	26.1	-3.3	1.053	0.5	0.5	0	41.3	29.7	0	131	103	0	35	34	35
2025	11	7	7	42	15	26.4	-1.6	1.053	0.5	0.4	0	43.4	31.4	0	136	107	0	35	34	34
2025	11	7	7	52	15	25.1	-3.1	1.053	0.5	0.4	0	41.3	29.7	0	131	103	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	7	8	2	15	26	-3.2	1.053	0.5	0.4	0	40.4	28.4	0	128	100	0	34	34	35
2025	11	7	8	12	15	25.5	-3	1.054	0.3	0.2	0	39.1	27.5	0	126	98	0	35	34	35
2025	11	7	8	22	15	26	-3.3	1.053	0.3	0.2	0	39.1	27.5	0	126	98	0	35	34	35
2025	11	7	8	32	15	25.3	-2.6	1.054	0.4	0.3	0	39.1	28	0	126	98	0	35	33	34
2025	11	7	8	42	15	26.3	-2.9	1.054	0.4	0.3	0	38.3	27.1	0	124	97	0	35	34	34
2025	11	7	8	52	15	25.8	-3.4	1.054	0.4	0.3	0	38.3	27.1	0	124	97	0	35	34	34
2025	11	7	9	2	15	25.6	-2.1	1.054	0.4	0.3	0	38.7	27.1	0	125	97	0	35	34	34
2025	11	7	9	12	15	26.4	-3.4	1.054	0.5	0.4	0	38.7	27.1	0	124	97	0	34	34	34
2025	11	7	9	22	15	23.5	-3	1.055	0.5	0.4	0	37.8	26.2	0	123	95	0	35	34	34
2025	11	7	9	32	15	24.7	-2.1	1.055	0.5	0.4	0	38.7	26.7	0	124	96	0	34	34	34
2025	11	7	9	42	15	25.1	-3	1.055	0.4	0.3	0	38.3	26.7	0	124	96	0	35	34	34
2025	11	7	9	52	15	24.9	-2.9	1.055	0.3	0.2	0	37.8	26.7	0	123	96	0	35	34	34
2025	11	7	10	2	15	25.5	-2.9	1.055	0.4	0.3	0	37.8	26.2	0	123	95	0	35	34	35
2025	11	7	10	12	15	26	-3.1	1.055	0.5	0.4	0	37.4	26.7	0	122	95	0	35	33	34
2025	11	7	10	22	15	25.4	-3.5	1.055	0.4	0.3	0	37.8	26.2	0	123	95	0	35	34	34
2025	11	7	10	32	15	26	-3.5	1.055	0.3	0.2	0	37.4	26.2	0	122	95	0	35	34	34
2025	11	7	10	42	15	24.7	-1.8	1.056	0.5	0.4	0	37.8	27.1	0	123	96	0	35	33	35
2025	11	7	10	52	15	24.7	-1.7	1.056	0.3	0.2	0	37.8	26.7	0	123	96	0	35	34	35
2025	11	7	11	2	15	25.7	-1.9	1.056	0.4	0.3	0	38.3	27.1	0	123	96	0	34	33	34
2025	11	7	11	12	15	25.8	-2.6	1.057	0.3	0.2	0	37.8	27.1	0	123	96	0	35	33	34
2025	11	7	11	22	15	26.2	-3	1.057	0.4	0.3	0	38.3	27.1	0	123	97	0	34	34	35
2025	11	7	11	32	15	25.8	-3.4	1.057	0.4	0.3	0	38.3	27.1	0	124	97	0	35	34	35
2025	11	7	11	42	15	25.4	-2.9	1.058	0.4	0.3	0	38.3	27.1	0	124	97	0	35	34	34
2025	11	7	11	52	15	26.4	-2.1	1.057	0.3	0.2	0	38.7	27.5	0	125	98	0	35	34	34
2025	11	7	12	2	15	26.2	-2.5	1.058	0.3	0.2	0	38.7	28	0	125	99	0	35	34	34
2025	11	7	12	12	15	25.8	-2.6	1.059	0.3	0.2	0	40.4	29.7	0	129	102	0	35	33	33
2025	11	7	12	22	15	26.2	-2.2	1.058	0.4	0.3	0	39.6	28.4	0	127	100	0	35	34	35
2025	11	7	12	32	15	26.1	-2.2	1.059	0.5	0.4	0	39.1	28.4	0	126	99	0	35	33	35
2025	11	7	12	42	15	24.2	-2.5	1.059	0.3	0.2	0	38.3	28	0	124	97	0	35	32	34
2025	11	7	12	52	15	25.9	-3.4	1.06	0.5	0.4	0	37.8	26.7	0	123	96	0	35	34	34
2025	11	7	13	2	15	25.4	-3.4	1.06	0.5	0.4	0	38.7	27.5	0	124	97	0	34	33	35
2025	11	7	13	12	15	25.1	-2.9	1.06	0.5	0.4	0	38.3	27.1	0	124	97	0	35	34	34
2025	11	7	13	22	15	26	-3.1	1.06	0.4	0.3	0	38.3	27.5	0	124	97	0	35	33	34
2025	11	7	13	32	15	25.4	-2.2	1.061	0.4	0.3	0	38.3	27.5	0	124	97	0	35	33	34
2025	11	7	13	42	15	25.7	-2.1	1.061	0.3	0.2	0	37.8	26.7	0	123	96	0	35	34	34
2025	11	7	13	52	15	25.4	-2.1	1.061	0.4	0.3	0	37.8	26.7	0	122	95	0	34	33	34
2025	11	7	14	2	15	25.9	-3.2	1.061	0.5	0.5	0	37.8	26.7	0	123	95	0	35	33	35
2025	11	7	14	12	15	25.7	-2.2	1.061	0.4	0.3	0	37.8	26.7	0	123	96	0	35	34	35
2025	11	7	14	22	15	25.7	-2.3	1.061	0.5	0.4	0	38.3	27.1	0	124	97	0	35	34	34
2025	11	7	14	32	15	25.9	-2.7	1.061	0.4	0.3	0	37.8	26.7	0	123	96	0	35	34	34
2025	11	7	14	42	15	25.4	-2.1	1.061	0.3	0.2	0	38.3	26.7	0	123	96	0	34	34	35
2025	11	7	14	52	15	25.7	-2	1.061	0.4	0.3	0	37.8	27.1	0	123	96	0	35	33	35
2025	11	7	15	2	15	25	-1.3	1.061	0.3	0.2	0	38.3	27.1	0	124	96	0	35	33	34
2025	11	7	15	12	15	25.8	-2.5	1.061	0.3	0.2	0	37.8	26.7	0	123	96	0	35	34	34
2025	11	7	15	22	15	24.9	-2.1	1.061	0.4	0.3	0	37.8	27.5	0	123	97	0	35	33	34
2025	11	7	15	32	15	24.5	-3	1.061	0.4	0.3	0	38.3	27.1	0	124	97	0	35	34	34
2025	11	7	15	42	15	24.4	-1.8	1.061	0.4	0.3	0	38.3	27.1	0	124	97	0	35	34	34
2025	11	7	15	52	15	26.3	-2.1	1.061	0.5	0.4	0	37.8	27.1	0	123	97	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	7	16	2	15	25.3	-2.3	1.061	0.4	0.3	0	38.3	26.7	0	124	96	0	35	34	34
2025	11	7	16	12	15	25.6	-3	1.062	0.3	0.2	0	38.3	27.1	0	124	97	0	35	34	34
2025	11	7	16	22	15	25.8	-2.6	1.062	0.3	0.2	0	37.4	26.7	0	122	95	0	35	33	35
2025	11	7	16	32	15	25	-3.1	1.062	0.3	0.2	0	38.3	27.1	0	124	97	0	35	34	34
2025	11	7	16	42	15	25.9	-2.7	1.061	0.4	0.3	0	37.8	27.1	0	123	96	0	35	33	34
2025	11	7	16	52	15	25.9	-2.4	1.062	0.4	0.3	0	37.8	26.7	0	122	95	0	34	33	34
2025	11	7	17	2	15	23.6	-1.9	1.062	0.3	0.2	0	38.3	26.7	0	123	96	0	34	34	35
2025	11	7	17	12	15	24.4	-3	1.063	0.3	0.2	0	37.8	27.1	0	123	96	0	35	33	35
2025	11	7	17	22	15	24.6	-1.2	1.062	0.3	0.2	0	38.3	27.1	0	123	97	0	34	34	35
2025	11	7	17	32	15	24.3	-1.7	1.063	0.5	0.4	0	38.7	28	0	125	98	0	35	33	35
2025	11	7	17	42	15	23.7	-1.7	1.063	0.4	0.3	0	37.8	27.1	0	124	97	0	36	34	35
2025	11	7	17	52	15	24.2	-2.3	1.062	0.3	0.2	0	38.7	27.5	0	125	97	0	35	33	34
2025	11	7	18	2	15	24.7	-2.3	1.063	0.4	0.3	0	38.3	27.1	0	124	97	0	35	34	35
2025	11	7	18	12	15	25.4	-3.4	1.063	0.4	0.3	0	40	28.8	0	128	100	0	35	33	34
2025	11	7	18	22	15	25.3	-2.3	1.063	0.4	0.3	0	40.4	28.4	0	128	99	0	34	33	35
2025	11	7	18	32	15	24.5	-3.4	1.063	0.5	0.4	0	40	28.8	0	128	100	0	35	33	35
2025	11	7	18	42	15	25.5	-2.6	1.063	0.3	0.2	0	40.4	28.8	0	129	100	0	35	33	34
2025	11	7	18	52	15	25.5	-3.8	1.063	0.3	0.2	0	40.9	28.4	0	129	100	0	34	34	34
2025	11	7	19	2	15	25.2	-3	1.063	0.4	0.3	0	40.4	29.2	0	129	101	0	35	33	34
2025	11	7	19	12	15	25.1	-1.6	1.063	0.4	0.3	0	40.4	29.2	0	129	101	0	35	33	34
2025	11	7	19	22	15	24.6	-2.2	1.063	0.3	0.2	0	40.9	29.2	0	129	101	0	34	33	34
2025	11	7	19	32	15	25.4	-3.4	1.063	0.5	0.4	0	40.9	29.2	0	129	101	0	34	33	35
2025	11	7	19	42	15	25.3	-2.3	1.063	0.3	0.2	0	40.4	28.8	0	129	101	0	35	34	35
2025	11	7	19	52	15	25.7	-2.5	1.063	0.5	0.4	0	40.9	30.1	0	130	103	0	35	33	34
2025	11	7	20	2	15	25.2	-2.5	1.063	0.5	0.4	0	41.3	30.1	0	130	103	0	34	33	35
2025	11	7	20	12	15	25.2	-2.2	1.063	0.4	0.3	0	41.3	30.1	0	130	103	0	34	33	34
2025	11	7	20	22	15	25.2	-2.1	1.063	0.5	0.4	0	41.3	29.2	0	130	102	0	34	34	34
2025	11	7	20	32	15	24.4	-3.2	1.063	0.5	0.4	0	41.3	30.1	0	131	103	0	35	33	35
2025	11	7	20	42	15	24.3	-2	1.063	0.4	0.3	0	41.3	30.1	0	131	104	0	35	34	34
2025	11	7	20	52	15	24.1	-1.4	1.063	0.3	0.2	0	41.7	30.1	0	132	104	0	35	34	35
2025	11	7	21	2	15	24.3	-2.5	1.063	0.4	0.3	0	41.7	30.1	0	132	104	0	35	34	34
2025	11	7	21	12	15	26	-2.4	1.063	0.5	0.5	0	41.7	30.1	0	131	103	0	34	33	34
2025	11	7	21	22	15	25.9	-2.9	1.063	0.4	0.3	0	40.9	29.7	0	130	103	0	35	34	34
2025	11	7	21	32	15	24.9	-2.2	1.063	0.3	0.2	0	41.3	29.7	0	131	103	0	35	34	35
2025	11	7	21	42	15	24.3	-2	1.063	0.3	0.2	0	41.3	30.1	0	131	104	0	35	34	34
2025	11	7	21	52	15	24.6	-3.6	1.063	0.3	0.2	0	40.9	29.7	0	130	102	0	35	33	34
2025	11	7	22	2	15	25.5	-2.2	1.063	0.3	0.2	0	41.7	29.7	0	132	103	0	35	34	35
2025	11	7	22	12	15	26.4	-2.4	1.063	0.5	0.4	0	41.3	29.2	0	131	102	0	35	34	35
2025	11	7	22	22	15	25.8	-1.6	1.064	0.3	0.2	0	42.6	30.1	0	133	104	0	34	34	34
2025	11	7	22	32	15	24.5	-2	1.064	0.4	0.3	0	41.7	29.7	0	132	103	0	35	34	35
2025	11	7	22	42	15	25.9	-2.9	1.063	0.4	0.3	0	41.7	29.2	0	132	102	0	35	34	35
2025	11	7	22	52	15	25.9	-3.3	1.063	0.3	0.2	0	41.7	30.1	0	132	103	0	35	33	34
2025	11	7	23	2	15	25.9	-3	1.063	0.4	0.3	0	42.1	29.2	0	132	102	0	34	34	35
2025	11	7	23	12	15	26.4	-3.1	1.064	0.4	0.3	0	41.7	29.7	0	132	103	0	35	34	34
2025	11	7	23	22	15	25.5	-3.2	1.064	0.4	0.3	0	41.3	29.2	0	131	102	0	35	34	35
2025	11	7	23	32	15	25.7	-3.3	1.064	0.3	0.2	0	41.7	29.7	0	132	103	0	35	34	35
2025	11	7	23	42	15	26.4	-2.9	1.064	0.3	0.2	0	41.7	29.7	0	132	102	0	35	33	35
2025	11	7	23	52	15	25.6	-3.4	1.064	0.3	0.2	0	41.7	29.2	0	132	102	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	8	0	2	15	26.7	-2.3	1.064	0.3	0.2	0	41.7	30.1	0	132	103	0	35	33	35
2025	11	8	0	12	15	25.6	-2.3	1.064	0.4	0.3	0	41.3	29.7	0	131	102	0	35	33	34
2025	11	8	0	22	15	25	-2.2	1.064	0.4	0.3	0	43.4	31.8	0	136	107	0	35	33	34
2025	11	8	0	32	15	25.8	-2.5	1.064	0.3	0.2	0	43.4	31	0	135	105	0	34	33	34
2025	11	8	0	42	15	24.4	-1.7	1.064	0.3	0.2	0	42.6	30.5	0	134	105	0	35	34	34
2025	11	8	0	52	15	26.2	-4	1.064	0.5	0.4	0	41.7	29.7	0	132	103	0	35	34	35
2025	11	8	1	2	15	26.8	-3.2	1.064	0.5	0.4	0	41.7	29.7	0	132	103	0	35	34	34
2025	11	8	1	12	15	26.7	-2.3	1.064	0.3	0.2	0	42.1	29.7	0	132	103	0	34	34	35
2025	11	8	1	22	15	26	-2.5	1.064	0.5	0.4	0	41.3	29.2	0	131	102	0	35	34	35
2025	11	8	1	32	15	24.6	-2.2	1.064	0.3	0.2	0	42.1	29.7	0	133	103	0	35	34	34
2025	11	8	1	42	15	26.2	-1.9	1.064	0.3	0.2	0	41.7	30.1	0	132	103	0	35	33	34
2025	11	8	1	52	15	24.8	-1.8	1.064	0.4	0.3	0	42.1	30.1	0	133	103	0	35	33	35
2025	11	8	2	2	15	25	-1.6	1.065	0.4	0.3	0	41.7	29.7	0	132	103	0	35	34	35
2025	11	8	2	12	15	25.1	-3.1	1.065	0.4	0.3	0	41.7	30.1	0	133	103	0	36	33	35
2025	11	8	2	22	15	25.9	-1.3	1.064	0.4	0.3	0	41.3	30.1	0	132	103	0	36	33	34
2025	11	8	2	32	15	26.1	-2.3	1.065	0.4	0.3	0	41.7	29.2	0	132	102	0	35	34	34
2025	11	8	2	42	15	24.9	-1.7	1.065	0.3	0.2	0	41.7	29.2	0	132	102	0	35	34	34
2025	11	8	2	52	15	25.4	-2.1	1.065	0.5	0.4	0	41.7	29.7	0	132	103	0	35	34	34
2025	11	8	3	2	15	26.7	-1.9	1.065	0.5	0.4	0	41.7	29.2	0	132	102	0	35	34	34
2025	11	8	3	12	15	25.8	-3.1	1.065	0.4	0.3	0	41.3	29.2	0	131	102	0	35	34	35
2025	11	8	3	22	15	25.6	-2.9	1.065	0.5	0.4	0	41.7	29.2	0	132	102	0	35	34	35
2025	11	8	3	32	15	25.7	-1.9	1.066	0.4	0.3	0	41.3	29.7	0	131	102	0	35	33	35
2025	11	8	3	42	15	26.4	-2.6	1.066	0.4	0.3	0	41.3	29.2	0	131	102	0	35	34	34
2025	11	8	3	52	15	26.7	-2.9	1.066	0.3	0.2	0	41.7	29.2	0	131	102	0	34	34	34
2025	11	8	4	2	15	25.2	-2.9	1.066	0.3	0.2	0	41.3	29.2	0	131	101	0	35	33	35
2025	11	8	4	12	15	26.3	-3.8	1.067	0.4	0.3	0	40.9	28.4	0	130	100	0	35	34	35
2025	11	8	4	22	15	25.2	-2.2	1.067	0.3	0.2	0	40.9	28.8	0	130	101	0	35	34	35
2025	11	8	4	32	15	25.7	-2.4	1.067	0.5	0.4	0	41.7	28.8	0	131	101	0	34	34	34
2025	11	8	4	42	15	26.7	-2.1	1.068	0.4	0.3	0	42.1	28.8	0	132	101	0	34	34	34
2025	11	8	4	52	15	25.9	-3.7	1.068	0.5	0.4	0	41.3	28.8	0	131	101	0	35	34	35
2025	11	8	5	2	15	25.2	-2.1	1.069	0.5	0.4	0	42.6	30.1	0	133	103	0	34	33	35
2025	11	8	5	12	15	26.2	-2.7	1.069	0.4	0.3	0	41.3	28.8	0	131	101	0	35	34	35
2025	11	8	5	22	15	26	-2.7	1.069	0.4	0.3	0	41.3	28.8	0	131	100	0	35	33	35
2025	11	8	5	32	15	24.1	-1.7	1.069	0.5	0.4	0	41.3	28.8	0	131	101	0	35	34	35
2025	11	8	5	42	15	25.2	-2.7	1.07	0.4	0.3	0	41.3	28.8	0	131	101	0	35	34	35
2025	11	8	5	52	15	25	-2.3	1.069	0.4	0.3	0	40.9	29.2	0	130	101	0	35	33	35
2025	11	8	6	2	15	26.5	-2.7	1.07	0.3	0.2	0	41.7	28.8	0	132	102	0	35	35	34
2025	11	8	6	12	15	25	-2.9	1.07	0.4	0.3	0	41.3	29.2	0	131	101	0	35	33	35
2025	11	8	6	22	15	26.3	-2.9	1.07	0.3	0.2	0	41.3	28.8	0	131	101	0	35	34	35
2025	11	8	6	32	15	25.3	-2	1.07	0.3	0.2	0	41.3	29.2	0	130	101	0	34	33	34
2025	11	8	6	42	15	25.8	-1.6	1.071	0.5	0.4	0	40.9	28.8	0	130	101	0	35	34	35
2025	11	8	6	52	15	25.9	-2.6	1.07	0.5	0.4	0	40	28.4	0	128	99	0	35	33	34
2025	11	8	7	2	15	25.7	-3	1.071	0.4	0.3	0	39.6	28	0	127	98	0	35	33	34
2025	11	8	7	12	15	26.4	-2.1	1.071	0.4	0.3	0	40	27.5	0	128	98	0	35	34	34
2025	11	8	7	22	15	26	-1.7	1.071	0.5	0.4	0	39.6	28	0	127	98	0	35	33	35
2025	11	8	7	32	15	24.8	-2.8	1.071	0.4	0.3	0	39.6	28	0	127	98	0	35	33	35
2025	11	8	7	42	15	24.4	-1.2	1.071	0.5	0.4	0	39.6	27.5	0	127	98	0	35	34	34
2025	11	8	7	52	15	26.3	-1.3	1.071	0.4	0.3	0	39.6	27.1	0	127	97	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	8	8	2	15	25.7	-2.1	1.072	0.3	0.2	0	39.6	27.5	0	127	97	0	35	33	34
2025	11	8	8	12	15	24	-2	1.072	0.3	0.2	0	39.6	28	0	127	98	0	35	33	34
2025	11	8	8	22	15	25.5	-1.8	1.072	0.3	0.2	0	39.6	27.5	0	127	98	0	35	34	35
2025	11	8	8	32	15	26.4	-1.6	1.072	0.4	0.3	0	39.1	27.1	0	126	97	0	35	34	35
2025	11	8	8	42	15	25	-2.3	1.072	0.5	0.4	0	39.1	27.1	0	126	97	0	35	34	34
2025	11	8	8	52	15	24.8	-2.6	1.072	0.5	0.4	0	38.7	27.1	0	125	97	0	35	34	35
2025	11	8	9	2	15	26.8	-1.9	1.072	0.4	0.3	0	39.1	27.1	0	126	97	0	35	34	34
2025	11	8	9	12	15	24.8	-1.7	1.073	0.4	0.3	0	38.7	27.1	0	125	97	0	35	34	35
2025	11	8	9	22	15	24.4	-1.6	1.073	0.4	0.3	0	38.7	27.1	0	125	97	0	35	34	34
2025	11	8	9	32	15	25.6	-2.6	1.073	0.4	0.3	0	38.7	27.1	0	124	96	0	34	33	35
2025	11	8	9	42	15	25.1	-1.2	1.073	0.5	0.4	0	38.3	26.7	0	124	96	0	35	34	34
2025	11	8	9	52	15	24.6	-1.1	1.074	0.4	0.3	0	39.1	26.7	0	125	96	0	34	34	35
2025	11	8	10	2	15	23.6	-1.3	1.074	0.4	0.3	0	38.7	27.5	0	125	97	0	35	33	34
2025	11	8	10	12	15	25.6	-2.5	1.074	0.5	0.4	0	38.7	26.7	0	124	96	0	34	34	35
2025	11	8	10	22	15	24.5	-2.1	1.074	0.4	0.3	0	38.3	26.7	0	124	96	0	35	34	34
2025	11	8	10	32	15	25.6	-2.8	1.074	0.3	0.2	0	37.8	26.2	0	123	95	0	35	34	34
2025	11	8	10	42	15	25.2	-1.6	1.074	0.5	0.4	0	38.3	27.1	0	124	96	0	35	33	34
2025	11	8	10	52	15	25.6	-1.2	1.074	0.4	0.3	0	38.3	27.1	0	124	97	0	35	34	35
2025	11	8	11	2	15	25.3	-3	1.074	0.3	0.2	0	38.7	27.5	0	125	97	0	35	33	35
2025	11	8	11	12	15	25.3	-1.7	1.075	0.4	0.3	0	38.7	26.7	0	124	96	0	34	34	34
2025	11	8	11	22	15	25.3	-1.8	1.075	0.3	0.2	0	38.7	27.5	0	125	97	0	35	33	34
2025	11	8	11	32	15	26.5	-1.8	1.075	0.3	0.2	0	39.1	27.5	0	125	98	0	34	34	35
2025	11	8	11	42	15	24.1	-1.2	1.075	0.4	0.3	0	38.7	27.5	0	125	97	0	35	33	34
2025	11	8	11	52	15	26	-2	1.075	0.4	0.3	0	38.7	27.1	0	125	97	0	35	34	34
2025	11	8	12	2	15	25.2	-1.8	1.075	0.5	0.4	0	38.7	28	0	125	98	0	35	33	35
2025	11	8	12	12	15	24.8	-2.4	1.075	0.4	0.3	0	38.7	27.1	0	125	97	0	35	34	35
2025	11	8	12	22	15	23.6	-1.7	1.075	0.4	0.3	0	38.3	26.7	0	124	96	0	35	34	35
2025	11	8	12	32	15	25.6	-1.6	1.075	0.4	0.3	0	37.8	27.1	0	123	96	0	35	33	34
2025	11	8	12	42	15	25	-2.6	1.075	0.3	0.2	0	38.3	26.7	0	124	96	0	35	34	34
2025	11	8	12	52	15	25.8	-1.3	1.076	0.3	0.2	0	39.1	28	0	126	98	0	35	33	35
2025	11	8	13	2	15	24.4	-1.2	1.075	0.4	0.3	0	38.7	26.2	0	124	95	0	34	34	34
2025	11	8	13	12	15	25.4	-1.7	1.076	0.3	0.2	0	37.8	26.2	0	123	95	0	35	34	34
2025	11	8	13	22	15	25.4	-2.2	1.076	0.4	0.3	0	37.8	26.2	0	123	95	0	35	34	34
2025	11	8	13	32	15	24.2	-1.5	1.076	0.3	0.2	0	37.8	26.7	0	123	95	0	35	33	35
2025	11	8	13	42	15	25.5	-2.1	1.076	0.3	0.2	0	37.4	25.8	0	122	94	0	35	34	35
2025	11	8	13	52	15	26.2	-2.5	1.076	0.3	0.2	0	38.3	25.8	0	123	94	0	34	34	34
2025	11	8	14	2	15	26	-1.5	1.076	0.4	0.3	0	37.8	26.7	0	123	95	0	35	33	34
2025	11	8	14	12	15	25.2	-2.3	1.076	0.3	0.2	0	37.8	25.8	0	123	94	0	35	34	34
2025	11	8	14	22	15	25.4	-2.5	1.076	0.5	0.4	0	37.4	25.8	0	122	94	0	35	34	34
2025	11	8	14	32	15	26.6	-2.1	1.076	0.5	0.4	0	37.4	25.4	0	122	93	0	35	34	35
2025	11	8	14	42	15	26.1	-1.7	1.076	0.4	0.3	0	37.8	25.8	0	123	94	0	35	34	35
2025	11	8	14	52	15	26.2	-2.1	1.076	0.4	0.3	0	37.4	26.2	0	122	94	0	35	33	34
2025	11	8	15	2	15	24.2	-2.3	1.076	0.4	0.3	0	37.4	26.2	0	122	94	0	35	33	34
2025	11	8	15	12	15	25	-2	1.076	0.5	0.4	0	37.8	25.8	0	123	94	0	35	34	34
2025	11	8	15	22	15	25.1	-2.2	1.076	0.3	0.2	0	38.3	26.2	0	123	94	0	34	33	34
2025	11	8	15	32	15	24.2	-1.8	1.076	0.4	0.3	0	37.8	26.2	0	123	94	0	35	33	35
2025	11	8	15	42	15	25.4	-2.5	1.076	0.4	0.3	0	38.3	25.8	0	123	94	0	34	34	35
2025	11	8	15	52	15	25.3	-1.7	1.076	0.5	0.4	0	38.3	26.2	0	123	95	0	34	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	8	16	2	15	25.6	-1.4	1.076	0.4	0.3	0	37.8	26.2	0	123	94	0	35	33	35
2025	11	8	16	12	15	25.7	-2.8	1.075	0.4	0.3	0	37.8	26.2	0	123	94	0	35	33	34
2025	11	8	16	22	15	25.6	-1.7	1.076	0.3	0.2	0	37.4	25.4	0	122	93	0	35	34	34
2025	11	8	16	32	15	25.8	-1.9	1.076	0.5	0.4	0	37.4	25.4	0	122	93	0	35	34	35
2025	11	8	16	42	15	26.5	-1.7	1.076	0.4	0.3	0	37.4	24.9	0	122	92	0	35	34	35
2025	11	8	16	52	15	24.9	-1.7	1.076	0.4	0.3	0	37.4	24.9	0	122	92	0	35	34	35
2025	11	8	17	2	15	26.2	-3	1.076	0.3	0.2	0	37.4	24.9	0	122	92	0	35	34	35
2025	11	8	17	12	15	25.4	-2.2	1.076	0.3	0.2	0	38.3	25.4	0	123	93	0	34	34	34
2025	11	8	17	22	15	25.9	-2.1	1.076	0.4	0.3	0	37.4	25.8	0	122	93	0	35	33	35
2025	11	8	17	32	15	24.9	-2.7	1.076	0.4	0.3	0	37.8	25.4	0	123	93	0	35	34	35
2025	11	8	17	42	15	26.2	-2.4	1.076	0.6	0.5	0	38.3	25.4	0	123	93	0	34	34	34
2025	11	8	17	52	15	26.1	-1.9	1.076	0.4	0.3	0	38.3	25.4	0	123	93	0	34	34	34
2025	11	8	18	2	15	25.3	-2.7	1.076	0.5	0.4	0	38.3	25.8	0	123	93	0	34	33	34
2025	11	8	18	12	15	25.5	-2.1	1.076	0.4	0.3	0	39.6	27.1	0	127	97	0	35	34	34
2025	11	8	18	22	15	25.1	-3.4	1.076	0.5	0.4	0	39.1	26.7	0	126	96	0	35	34	34
2025	11	8	18	32	15	25.3	-2.4	1.076	0.4	0.3	0	39.6	27.5	0	127	97	0	35	33	34
2025	11	8	18	42	15	24.1	-2.1	1.076	0.5	0.4	0	40.9	28	0	129	99	0	34	34	35
2025	11	8	18	52	15	24.8	-2.5	1.076	0.4	0.3	0	40.4	28	0	129	98	0	35	33	34
2025	11	8	19	2	15	26.5	-2.2	1.076	0.4	0.3	0	40.4	28	0	129	99	0	35	34	35
2025	11	8	19	12	15	26.6	-2.1	1.076	0.5	0.5	0	40	28	0	128	98	0	35	33	34
2025	11	8	19	22	15	25.7	-2.5	1.076	0.4	0.3	0	40.4	28.4	0	129	100	0	35	34	35
2025	11	8	19	32	15	25.6	-2.2	1.077	0.5	0.5	0	40.9	28.4	0	129	100	0	34	34	35
2025	11	8	19	42	15	25.8	-2.8	1.076	0.4	0.3	0	41.7	29.2	0	131	102	0	34	34	34
2025	11	8	19	52	15	25.8	-2.5	1.076	0.4	0.3	0	41.3	29.7	0	131	102	0	35	33	34
2025	11	8	20	2	15	25.7	-1.7	1.076	0.4	0.3	0	41.7	29.2	0	132	102	0	35	34	35
2025	11	8	20	12	15	25.9	-2.2	1.077	0.4	0.3	0	41.7	30.1	0	132	103	0	35	33	35
2025	11	8	20	22	15	26.2	-3.2	1.076	0.5	0.4	0	41.3	29.7	0	131	102	0	35	33	35
2025	11	8	20	32	15	25.3	-1.7	1.077	0.3	0.2	0	41.3	29.2	0	131	102	0	35	34	34
2025	11	8	20	42	15	25.9	-3.7	1.076	0.5	0.4	0	41.3	28.8	0	131	101	0	35	34	35
2025	11	8	20	52	15	25.9	-1.9	1.076	0.4	0.3	0	41.3	28.8	0	131	101	0	35	34	34
2025	11	8	21	2	15	27	-3.5	1.076	0.5	0.4	0	41.3	28.8	0	131	102	0	35	35	34
2025	11	8	21	12	15	25.9	-2.9	1.076	0.4	0.3	0	42.1	29.7	0	133	103	0	35	34	34
2025	11	8	21	22	15	26.1	-2.6	1.077	0.4	0.3	0	41.7	29.7	0	132	102	0	35	33	35
2025	11	8	21	32	15	25.2	-1.8	1.077	0.4	0.3	0	41.7	29.2	0	132	102	0	35	34	35
2025	11	8	21	42	15	26.4	-2.9	1.077	0.4	0.3	0	41.3	29.2	0	131	101	0	35	33	34
2025	11	8	21	52	15	27.2	-2.7	1.077	0.3	0.2	0	42.1	29.7	0	132	102	0	34	33	35
2025	11	8	22	2	15	26	-2.4	1.076	0.4	0.3	0	41.7	29.2	0	132	102	0	35	34	34
2025	11	8	22	12	15	25.8	-2.5	1.077	0.5	0.5	0	41.7	29.7	0	132	102	0	35	33	34
2025	11	8	22	22	15	26.9	-4.4	1.077	0.4	0.3	0	41.3	29.2	0	131	101	0	35	33	35
2025	11	8	22	32	15	26.3	-3	1.077	0.4	0.3	0	41.7	28.8	0	131	101	0	34	34	34
2025	11	8	22	42	15	26.2	-2.2	1.077	0.5	0.4	0	41.3	28.8	0	131	101	0	35	34	35
2025	11	8	22	52	15	25.9	-2.5	1.077	0.3	0.2	0	41.7	29.2	0	132	102	0	35	34	34
2025	11	8	23	2	15	24.7	-2.1	1.077	0.5	0.5	0	41.7	29.2	0	132	102	0	35	34	35
2025	11	8	23	12	15	27.4	-3.4	1.077	0.4	0.3	0	41.3	28.8	0	131	101	0	35	34	34
2025	11	8	23	22	15	27	-2.9	1.077	0.4	0.3	0	41.7	28.8	0	132	101	0	35	34	34
2025	11	8	23	32	15	27.3	-3	1.076	0.4	0.3	0	41.3	28.4	0	131	100	0	35	34	34
2025	11	8	23	42	15	25.5	-2.8	1.077	0.4	0.3	0	41.7	28.8	0	132	101	0	35	34	34
2025	11	8	23	52	15	26.6	-2.6	1.077	0.4	0.3	0	41.7	28.8	0	132	101	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	9	0	2	15	25.1	-3.7	1.077	0.4	0.3	0	42.1	29.2	0	133	102	0	35	34	34
2025	11	9	0	12	15	25	-2	1.077	0.3	0.2	0	42.6	29.2	0	133	102	0	34	34	35
2025	11	9	0	22	15	25.6	-2.5	1.077	0.3	0.2	0	41.3	28.4	0	131	100	0	35	34	35
2025	11	9	0	32	15	26.1	-2	1.077	0.4	0.3	0	42.1	29.2	0	133	101	0	35	33	35
2025	11	9	0	42	15	25.6	-1.6	1.077	0.4	0.3	0	42.6	29.7	0	134	103	0	35	34	34
2025	11	9	0	52	15	25.9	-1.6	1.077	0.4	0.3	0	43	30.1	0	134	103	0	34	33	34
2025	11	9	1	2	15	27.7	-3.3	1.077	0.4	0.3	0	41.7	28.8	0	131	100	0	34	33	34
2025	11	9	1	12	15	26.7	-4.2	1.077	0.3	0.2	0	42.1	28.8	0	132	101	0	34	34	35
2025	11	9	1	22	15	25.1	-1.6	1.077	0.4	0.3	0	42.6	30.1	0	134	103	0	35	33	34
2025	11	9	1	32	15	27.4	-2.5	1.077	0.4	0.3	0	41.7	28.8	0	132	100	0	35	33	34
2025	11	9	1	42	15	26.7	-3.8	1.077	0.5	0.4	0	41.7	28.4	0	132	100	0	35	34	34
2025	11	9	1	52	15	27.4	-2.5	1.077	0.3	0.2	0	42.1	28.8	0	132	101	0	34	34	34
2025	11	9	2	2	15	24.6	-2.7	1.077	0.4	0.3	0	41.7	28.8	0	132	101	0	35	34	35
2025	11	9	2	12	15	26.5	-3.3	1.077	0.3	0.2	0	40.9	28	0	130	99	0	35	34	34
2025	11	9	2	22	15	26.6	-2.9	1.077	0.3	0.2	0	40.9	28.4	0	130	99	0	35	33	34
2025	11	9	2	32	15	25.2	-2.2	1.077	0.3	0.2	0	41.7	28.4	0	132	100	0	35	34	34
2025	11	9	2	42	15	25.3	-2.5	1.077	0.3	0.2	0	41.3	28.4	0	131	100	0	35	34	34
2025	11	9	2	52	15	27.2	-2.8	1.077	0.4	0.3	0	40.9	28	0	130	99	0	35	34	35
2025	11	9	3	2	15	25.6	-2.6	1.077	0.3	0.2	0	40.9	28	0	130	99	0	35	34	34
2025	11	9	3	12	15	25.6	-3.6	1.077	0.4	0.3	0	41.7	28.4	0	131	99	0	34	33	34
2025	11	9	3	22	15	25.9	-3.1	1.077	0.3	0.2	0	40.4	27.5	0	129	98	0	35	34	34
2025	11	9	3	32	15	25.9	-2.3	1.077	0.4	0.3	0	40.9	28	0	130	99	0	35	34	34
2025	11	9	3	42	15	26.3	-2.1	1.077	0.3	0.2	0	41.3	27.5	0	130	98	0	34	34	35
2025	11	9	3	52	15	25.2	-2.4	1.077	0.4	0.3	0	40.9	27.5	0	130	98	0	35	34	35
2025	11	9	4	2	15	26.4	-1.8	1.077	0.4	0.3	0	40.4	27.5	0	129	98	0	35	34	35
2025	11	9	4	12	15	26.3	-2.1	1.077	0.3	0.2	0	40.9	27.5	0	129	97	0	34	33	35
2025	11	9	4	22	15	26.7	-3	1.077	0.5	0.4	0	40	27.1	0	128	97	0	35	34	34
2025	11	9	4	32	15	26.9	-3.9	1.077	0.4	0.3	0	40	26.7	0	128	96	0	35	34	35
2025	11	9	4	42	15	26.4	-3.1	1.078	0.5	0.4	0	40.4	27.1	0	128	97	0	34	34	34
2025	11	9	4	52	15	25.9	-2.3	1.077	0.3	0.2	0	40	27.1	0	127	96	0	34	33	34
2025	11	9	5	2	15	26.4	-2.3	1.077	0.5	0.4	0	39.6	27.1	0	127	96	0	35	33	34
2025	11	9	5	12	15	26.8	-2.2	1.078	0.3	0.2	0	40	27.1	0	128	96	0	35	33	35
2025	11	9	5	22	15	26.1	-2.9	1.078	0.5	0.4	0	40	26.7	0	128	96	0	35	34	35
2025	11	9	5	32	15	27.3	-3.2	1.078	0.5	0.4	0	40	26.7	0	128	96	0	35	34	35
2025	11	9	5	42	15	26.2	-4	1.078	0.4	0.3	0	40.4	27.1	0	129	97	0	35	34	34
2025	11	9	5	52	15	26.3	-3.8	1.078	0.5	0.4	0	40	26.7	0	128	95	0	35	33	34
2025	11	9	6	2	15	25.6	-2.5	1.078	0.4	0.3	0	40.4	26.7	0	129	96	0	35	34	35
2025	11	9	6	12	15	26.7	-2.1	1.078	0.3	0.2	0	40	26.2	0	128	95	0	35	34	34
2025	11	9	6	22	15	26.7	-2.1	1.079	0.4	0.3	0	40	26.7	0	128	96	0	35	34	34
2025	11	9	6	32	15	26	-2.1	1.079	0.4	0.3	0	40	27.1	0	128	96	0	35	33	35
2025	11	9	6	42	15	27.2	-3.1	1.079	0.4	0.3	0	40	25.8	0	127	94	0	34	34	35
2025	11	9	6	52	15	26.1	-3.8	1.079	0.3	0.2	0	39.6	26.2	0	126	94	0	34	33	35
2025	11	9	7	2	15	26.2	-2.5	1.079	0.4	0.3	0	39.6	26.2	0	126	94	0	34	33	35
2025	11	9	7	12	15	26.1	-2.9	1.079	0.3	0.2	0	39.6	25.8	0	126	94	0	34	34	35
2025	11	9	7	22	15	26.4	-3.8	1.08	0.5	0.4	0	39.1	25.8	0	126	94	0	35	34	34
2025	11	9	7	32	15	25.7	-3.8	1.079	0.4	0.3	0	38.7	25.4	0	125	93	0	35	34	34
2025	11	9	7	42	15	26.2	-3	1.079	0.5	0.4	0	39.1	25.4	0	125	93	0	34	34	34
2025	11	9	7	52	15	27.2	-3.3	1.079	0.4	0.3	0	39.1	25.4	0	126	93	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	9	8	2	15	26.3	-2.4	1.079	0.4	0.3	0	38.7	25.4	0	125	93	0	35	34	35
2025	11	9	8	12	15	26.1	-2.8	1.08	0.5	0.4	0	38.7	25.4	0	124	93	0	34	34	34
2025	11	9	8	22	15	25.9	-2.8	1.08	0.3	0.2	0	39.1	25.8	0	125	93	0	34	33	34
2025	11	9	8	32	15	26	-2.2	1.08	0.3	0.2	0	38.7	25.4	0	125	93	0	35	34	35
2025	11	9	8	42	15	26.5	-3.3	1.08	0.4	0.3	0	38.7	25.8	0	124	93	0	34	33	35
2025	11	9	8	52	15	25.1	-2.7	1.081	0.3	0.2	0	38.3	25.8	0	124	93	0	35	33	34
2025	11	9	9	2	15	25.2	-2.7	1.081	0.4	0.3	0	38.3	25.4	0	124	93	0	35	34	35
2025	11	9	9	12	15	24.7	-2.1	1.081	0.5	0.4	0	38.3	25.4	0	124	93	0	35	34	35
2025	11	9	9	22	15	24.3	-1.2	1.081	0.4	0.3	0	37.8	24.5	0	123	92	0	35	35	35
2025	11	9	9	32	15	25	-0.8	1.081	0.5	0.4	0	37.8	24.9	0	123	92	0	35	34	34
2025	11	9	9	42	15	25.6	-1.4	1.081	0.4	0.3	0	37.8	24.9	0	123	92	0	35	34	34
2025	11	9	9	52	15	24.8	-1.7	1.081	0.4	0.3	0	38.3	25.4	0	123	92	0	34	33	34
2025	11	9	10	2	15	23.9	-0.8	1.081	0.3	0.2	0	37.8	24.9	0	123	92	0	35	34	35
2025	11	9	10	12	15	24.5	-0.2	1.081	0.4	0.3	0	37.4	25.4	0	122	92	0	35	33	35
2025	11	9	10	22	15	24	-0.5	1.082	0.5	0.4	0	38.3	25.4	0	123	93	0	34	34	35
2025	11	9	10	32	15	23.6	-1.3	1.081	0.3	0.2	0	37.4	24.9	0	122	92	0	35	34	34
2025	11	9	10	42	15	24.8	-0.8	1.082	0.4	0.3	0	37.8	24.9	0	122	92	0	34	34	35
2025	11	9	10	52	15	24.9	-2.2	1.082	0.4	0.3	0	37.4	24.9	0	122	92	0	35	34	34
2025	11	9	11	2	15	24.1	-0.8	1.082	0.3	0.2	0	37.4	24.9	0	122	92	0	35	34	34
2025	11	9	11	12	15	25.4	-1.9	1.082	0.5	0.5	0	37.8	24.9	0	122	92	0	34	34	34
2025	11	9	11	22	15	25.6	-0.6	1.082	0.4	0.3	0	37.4	24.9	0	122	92	0	35	34	35
2025	11	9	11	32	15	24.4	-2.1	1.082	0.3	0.2	0	37	24.9	0	121	91	0	35	33	35
2025	11	9	11	42	15	25.9	-1.9	1.082	0.3	0.2	0	37	24.9	0	121	91	0	35	33	34
2025	11	9	11	52	15	25.7	-1.8	1.082	0.5	0.4	0	37.4	24.9	0	122	91	0	35	33	34
2025	11	9	12	2	15	27	-3	1.082	0.3	0.2	0	37	24.1	0	121	90	0	35	34	35
2025	11	9	12	12	15	26.4	-2.2	1.082	0.3	0.2	0	37	23.6	0	121	90	0	35	35	35
2025	11	9	12	22	15	26	-2.1	1.082	0.4	0.3	0	37	24.5	0	121	91	0	35	34	34
2025	11	9	12	32	15	25.1	-1.6	1.083	0.4	0.3	0	37.4	24.5	0	122	91	0	35	34	35
2025	11	9	12	42	15	25.9	-2.7	1.082	0.3	0.2	0	37.4	24.9	0	122	91	0	35	33	35
2025	11	9	12	52	15	25.2	-2.5	1.083	0.5	0.4	0	37.4	24.5	0	122	91	0	35	34	34
2025	11	9	13	2	15	25.9	-1.7	1.083	0.3	0.2	0	37	24.5	0	121	91	0	35	34	35
2025	11	9	13	12	15	25.4	-2.1	1.083	0.3	0.2	0	37.4	24.5	0	121	90	0	34	33	34
2025	11	9	13	22	15	24.7	-1.8	1.083	0.5	0.5	0	37.4	24.5	0	122	91	0	35	34	35
2025	11	9	13	32	15	25.7	-2.5	1.083	0.4	0.3	0	37	24.5	0	121	90	0	35	33	35
2025	11	9	13	42	15	25.2	-2.1	1.083	0.4	0.3	0	37	24.1	0	121	90	0	35	34	34
2025	11	9	13	52	15	25.1	-3.4	1.083	0.4	0.3	0	37	24.5	0	121	91	0	35	34	34
2025	11	9	14	2	15	25.3	-1.7	1.083	0.3	0.2	0	37	24.5	0	121	91	0	35	34	35
2025	11	9	14	12	15	25.7	-3.4	1.083	0.4	0.3	0	37.4	24.1	0	121	90	0	34	34	34
2025	11	9	14	22	15	25.1	-1.4	1.083	0.4	0.3	0	37	24.1	0	121	90	0	35	34	35
2025	11	9	14	32	15	24.7	-2	1.083	0.3	0.2	0	37	24.1	0	121	90	0	35	34	34
2025	11	9	14	42	15	26.1	-3	1.083	0.4	0.3	0	37	23.6	0	121	89	0	35	34	35
2025	11	9	14	52	15	25.9	-2.9	1.083	0.4	0.3	0	37.4	24.5	0	121	90	0	34	33	34
2025	11	9	15	2	15	25.5	-1.3	1.083	0.5	0.5	0	37.8	24.5	0	122	91	0	34	34	35
2025	11	9	15	12	15	24.5	-2.1	1.083	0.3	0.2	0	37.8	25.4	0	123	92	0	35	33	35
2025	11	9	15	22	15	25.7	-2.9	1.083	0.3	0.2	0	37.4	24.5	0	122	91	0	35	34	35
2025	11	9	15	32	15	26.5	-2.3	1.083	0.3	0.2	0	37.4	24.9	0	122	92	0	35	34	34
2025	11	9	15	42	15	26.1	-2.5	1.083	0.4	0.3	0	37.8	25.8	0	122	93	0	34	33	34
2025	11	9	15	52	15	25.5	-2.3	1.083	0.3	0.2	0	37.4	25.4	0	122	92	0	35	33	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	9	16	2	15	26	-2.6	1.083	0.3	0.2	0	38.3	25.8	0	124	93	0	35	33	34
2025	11	9	16	12	15	25.6	-2.6	1.083	0.4	0.3	0	37.4	24.5	0	122	91	0	35	34	34
2025	11	9	16	22	15	25.5	-3.3	1.083	0.4	0.3	0	37	24.9	0	121	91	0	35	33	34
2025	11	9	16	32	15	25.5	-2.6	1.083	0.4	0.3	0	36.5	23.6	0	120	89	0	35	34	34
2025	11	9	16	42	15	25	-2.8	1.083	0.4	0.3	0	37	23.6	0	121	89	0	35	34	35
2025	11	9	16	52	15	25.6	-1.6	1.083	0.5	0.4	0	36.5	23.2	0	120	88	0	35	34	35
2025	11	9	17	2	15	26.2	-2.5	1.083	0.4	0.3	0	37	23.6	0	121	89	0	35	34	35
2025	11	9	17	12	15	27.5	-1.2	1.083	0.4	0.3	0	37.4	24.5	0	122	91	0	35	34	34
2025	11	9	17	22	15	25.2	-1.7	1.083	0.3	0.2	0	37.8	24.5	0	122	91	0	34	34	34
2025	11	9	17	32	15	25.5	-2	1.083	0.4	0.3	0	37.4	25.4	0	122	92	0	35	33	34
2025	11	9	17	42	15	25.6	-2.4	1.083	0.3	0.2	0	37.4	24.5	0	122	91	0	35	34	34
2025	11	9	17	52	15	25.6	-2.2	1.083	0.3	0.2	0	37.4	24.9	0	122	91	0	35	33	34
2025	11	9	18	2	15	25.3	-1.8	1.083	0.3	0.2	0	37.8	24.9	0	122	91	0	34	33	34
2025	11	9	18	12	15	26.5	-2.1	1.083	0.3	0.2	0	37.8	24.5	0	123	91	0	35	34	35
2025	11	9	18	22	15	25	-1.7	1.083	0.4	0.3	0	38.3	24.9	0	124	92	0	35	34	35
2025	11	9	18	32	15	25.9	-3.5	1.083	0.4	0.3	0	38.7	25.4	0	125	93	0	35	34	34
2025	11	9	18	42	15	26.4	-2.7	1.083	0.3	0.2	0	39.1	25.8	0	125	93	0	34	33	34
2025	11	9	18	52	15	25.8	-3.3	1.083	0.4	0.3	0	38.7	24.9	0	124	92	0	34	34	35
2025	11	9	19	2	15	26.9	-2.4	1.083	0.4	0.3	0	38.7	25.4	0	125	93	0	35	34	35
2025	11	9	19	12	15	26.7	-2.7	1.083	0.5	0.4	0	39.6	26.2	0	127	95	0	35	34	34
2025	11	9	19	22	15	25.9	-2.9	1.083	0.3	0.2	0	40	26.2	0	128	95	0	35	34	34
2025	11	9	19	32	15	26.9	-2.8	1.083	0.3	0.2	0	40.4	26.2	0	128	95	0	34	34	34
2025	11	9	19	42	15	26.1	-2.6	1.083	0.3	0.2	0	40.4	26.2	0	128	95	0	34	34	34
2025	11	9	19	52	15	26.7	-2.9	1.083	0.3	0.2	0	40.9	27.1	0	130	97	0	35	34	34
2025	11	9	20	2	15	26.5	-2.2	1.083	0.3	0.2	0	40.9	27.1	0	130	96	0	35	33	35
2025	11	9	20	12	15	26.1	-2.8	1.083	0.4	0.3	0	40.9	27.1	0	130	96	0	35	33	35
2025	11	9	20	22	15	25.2	-3.5	1.083	0.4	0.3	0	40.9	27.5	0	130	97	0	35	33	34
2025	11	9	20	32	15	26.2	-2.7	1.083	0.4	0.3	0	41.7	27.5	0	131	98	0	34	34	34
2025	11	9	20	42	15	26.4	-2.6	1.083	0.5	0.5	0	40.4	27.1	0	129	96	0	35	33	34
2025	11	9	20	52	15	27.2	-3.9	1.083	0.5	0.4	0	40.4	26.7	0	129	96	0	35	34	35
2025	11	9	21	2	15	26.1	-2.6	1.083	0.3	0.2	0	40.9	27.5	0	130	97	0	35	33	34
2025	11	9	21	12	15	25.9	-2.9	1.083	0.5	0.4	0	41.3	27.5	0	130	97	0	34	33	35
2025	11	9	21	22	15	27.6	-3	1.083	0.5	0.4	0	40.9	27.5	0	130	97	0	35	33	35
2025	11	9	21	32	15	26	-2.9	1.083	0.4	0.3	0	40.4	27.1	0	129	96	0	35	33	34
2025	11	9	21	42	15	24.2	-3	1.083	0.3	0.2	0	41.3	27.5	0	131	97	0	35	33	34
2025	11	9	21	52	15	26.3	-2.9	1.083	0.4	0.3	0	40.9	27.1	0	130	97	0	35	34	35
2025	11	9	22	2	15	25	-2.1	1.083	0.4	0.3	0	40.9	27.1	0	130	97	0	35	34	35
2025	11	9	22	12	15	26	-3.5	1.083	0.5	0.4	0	40.9	27.1	0	130	97	0	35	34	34
2025	11	9	22	22	15	26.1	-2.5	1.083	0.4	0.3	0	40.9	27.1	0	130	97	0	35	34	35
2025	11	9	22	32	15	25.8	-2	1.083	0.5	0.4	0	40.4	27.5	0	129	97	0	35	33	34
2025	11	9	22	42	15	25	-3.2	1.083	0.3	0.2	0	40.9	27.5	0	130	97	0	35	33	34
2025	11	9	22	52	15	24.9	-1.9	1.083	0.3	0.2	0	40.9	27.1	0	130	97	0	35	34	34
2025	11	9	23	2	15	25.7	-1.9	1.082	0.3	0.2	0	40.4	26.7	0	129	96	0	35	34	35
2025	11	9	23	12	15	26.9	-3.3	1.083	0.4	0.3	0	40.4	27.1	0	129	96	0	35	33	34
2025	11	9	23	22	15	26	-2.4	1.083	0.5	0.5	0	40.9	27.1	0	130	97	0	35	34	34
2025	11	9	23	32	15	26.6	-2.5	1.083	0.4	0.3	0	40.9	27.1	0	130	97	0	35	34	35
2025	11	9	23	42	15	26.6	-3.7	1.083	0.5	0.5	0	40.4	26.7	0	129	96	0	35	34	35
2025	11	9	23	52	15	25.8	-2.3	1.083	0.4	0.3	0	40.4	26.7	0	129	96	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	10	0	2	15	25.8	-1.9	1.083	0.3	0.2	0	38.7	26.7	0	125	96	0	35	34	34
2025	11	10	0	12	15	27.3	-2.4	1.082	0.3	0.2	0	40.4	26.2	0	129	95	0	35	34	34
2025	11	10	0	22	15	26.3	-3.3	1.082	0.5	0.4	0	40	26.7	0	128	95	0	35	33	34
2025	11	10	0	32	15	25.5	-2.7	1.082	0.5	0.4	0	40.4	26.2	0	129	95	0	35	34	35
2025	11	10	0	42	15	26.8	-3.5	1.083	0.4	0.3	0	40	26.2	0	128	95	0	35	34	34
2025	11	10	0	52	15	26.1	-2.5	1.082	0.4	0.3	0	40	26.2	0	128	95	0	35	34	34
2025	11	10	1	2	15	26.9	-3.7	1.082	0.5	0.4	0	40	26.2	0	128	95	0	35	34	35
2025	11	10	1	12	15	26.2	-2.9	1.082	0.4	0.3	0	40.4	26.2	0	129	95	0	35	34	35
2025	11	10	1	22	15	26	-2.9	1.082	0.4	0.3	0	40	26.2	0	128	95	0	35	34	34
2025	11	10	1	32	15	25.4	-2.9	1.082	0.5	0.4	0	40	25.8	0	128	94	0	35	34	34
2025	11	10	1	42	15	26.6	-2.5	1.082	0.3	0.2	0	40.4	26.2	0	128	95	0	34	34	35
2025	11	10	1	52	15	27.4	-2.7	1.082	0.3	0.2	0	39.6	25.8	0	127	93	0	35	33	34
2025	11	10	2	2	15	26.7	-1.3	1.082	0.3	0.2	0	39.6	25.8	0	127	94	0	35	34	35
2025	11	10	2	12	15	26.7	-2.8	1.082	0.4	0.3	0	39.6	25.8	0	127	93	0	35	33	34
2025	11	10	2	22	15	26.5	-3.2	1.082	0.5	0.4	0	39.6	25.8	0	127	94	0	35	34	35
2025	11	10	2	32	15	26.6	-2.4	1.082	0.4	0.3	0	39.6	26.2	0	127	94	0	35	33	34
2025	11	10	2	42	15	27.1	-3	1.082	0.4	0.3	0	39.1	25.4	0	126	93	0	35	34	35
2025	11	10	2	52	15	26.8	-2.7	1.082	0.4	0.3	0	39.6	25.4	0	127	93	0	35	34	35
2025	11	10	3	2	15	26.9	-2.5	1.082	0.4	0.3	0	39.1	25.4	0	126	93	0	35	34	34
2025	11	10	3	12	15	26.6	-2.1	1.082	0.3	0.2	0	39.6	25.4	0	127	93	0	35	34	35
2025	11	10	3	22	15	24.8	-1.6	1.082	0.4	0.3	0	39.1	25.4	0	126	93	0	35	34	34
2025	11	10	3	32	15	26.7	-2.9	1.082	0.4	0.3	0	38.7	24.9	0	125	92	0	35	34	34
2025	11	10	3	42	15	27.4	-1.7	1.082	0.3	0.2	0	38.7	24.9	0	125	91	0	35	33	34
2025	11	10	3	52	15	27.3	-2.5	1.082	0.3	0.2	0	38.3	24.5	0	124	91	0	35	34	35
2025	11	10	4	2	15	27.6	-2.7	1.082	0.5	0.4	0	38.7	24.5	0	125	91	0	35	34	35
2025	11	10	4	12	15	25.9	-2.5	1.082	0.5	0.4	0	38.3	24.5	0	124	91	0	35	34	34
2025	11	10	4	22	15	25.9	-2.1	1.082	0.4	0.3	0	37.8	24.5	0	123	91	0	35	34	34
2025	11	10	4	32	15	26.5	-2.7	1.082	0.4	0.3	0	37.8	24.1	0	123	90	0	35	34	34
2025	11	10	4	42	15	25.3	-2.9	1.082	0.3	0.2	0	37.8	24.5	0	123	90	0	35	33	34
2025	11	10	4	52	15	27	-3	1.082	0.4	0.3	0	37.8	24.5	0	123	91	0	35	34	35
2025	11	10	5	2	15	26.3	-2.2	1.082	0.3	0.2	0	37.8	24.5	0	123	91	0	35	34	35
2025	11	10	5	12	15	27	-2.2	1.082	0.4	0.3	0	37.8	24.1	0	123	90	0	35	34	34
2025	11	10	5	22	15	26.3	-2	1.082	0.4	0.3	0	37.8	24.5	0	123	91	0	35	34	35
2025	11	10	5	32	15	26	-1.4	1.082	0.4	0.3	0	37.8	24.5	0	123	90	0	35	33	35
2025	11	10	5	42	15	24.7	-1.9	1.082	0.3	0.2	0	37.8	24.1	0	123	90	0	35	34	35
2025	11	10	5	52	15	23.7	-1.3	1.082	0.4	0.3	0	37.8	24.1	0	123	91	0	35	35	35
2025	11	10	6	2	15	26	-1.2	1.082	0.5	0.4	0	37.8	24.1	0	123	90	0	35	34	34
2025	11	10	6	12	15	26.1	-1.3	1.082	0.3	0.2	0	37.8	24.5	0	123	90	0	35	33	34
2025	11	10	6	22	15	24.8	-1.6	1.082	0.3	0.2	0	37.8	24.5	0	123	91	0	35	34	34
2025	11	10	6	32	15	24.7	-2.2	1.082	0.5	0.4	0	37.8	24.1	0	122	90	0	34	34	35
2025	11	10	6	42	15	25.8	-1.9	1.082	0.4	0.3	0	37.4	24.1	0	122	90	0	35	34	34
2025	11	10	6	52	15	26	-0.9	1.082	0.4	0.3	0	37.8	24.1	0	123	90	0	35	34	34
2025	11	10	7	2	15	25.5	-2.5	1.082	0.3	0.2	0	37.4	24.5	0	122	90	0	35	33	35
2025	11	10	7	12	15	25.1	-2.9	1.082	0.4	0.3	0	37.4	24.1	0	122	90	0	35	34	35
2025	11	10	7	22	15	26.4	-2.6	1.082	0.4	0.3	0	37.4	23.6	0	122	90	0	35	35	34
2025	11	10	7	32	15	25.7	-2	1.082	0.5	0.4	0	37.8	23.6	0	122	89	0	34	34	35
2025	11	10	7	42	15	26	-3	1.082	0.3	0.2	0	37.4	23.6	0	122	89	0	35	34	35
2025	11	10	7	52	15	25.6	-2	1.082	0.5	0.4	0	37.4	24.1	0	122	89	0	35	33	34

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	11	10	8	2	15	24.7	-2.1	1.082	0.3	0.2	0	37.4	23.6	0	121	89	0	34	34	35	
2025	11	10	8	12	15	24.9	-1.2	1.082	0.3	0.2	0	37.4	24.1	0	122	90	0	35	34	35	
2025	11	10	8	22	15	26	-1.6	1.082	0.4	0.3	0	37	23.6	0	121	89	0	35	34	35	
2025	11	10	8	32	15	25	-1.1	1.082	0.4	0.3	0	37	24.1	0	121	90	0	35	34	34	
2025	11	10	8	42	15	23.6	-1.5	1.082	0.3	0.2	0	37	23.6	0	121	89	0	35	34	34	
2025	11	10	8	52	15	25.4	-1.5	1.082	0.3	0.2	0	37	24.1	0	121	89	0	35	33	35	
2025	11	10	9	2	15	24.4	-1.4	1.082	0.5	0.4	0	37	24.1	0	121	89	0	35	33	34	
2025	11	10	9	12	15	25.5	-2.1	1.082	0.3	0.2	0	37	23.6	0	121	89	0	35	34	35	
2025	11	10	9	22	15	25.5	-2.2	1.082	0.4	0.3	0	37	24.1	0	121	89	0	35	33	35	
2025	11	10	9	32	15	25.4	-1.4	1.082	0.5	0.4	0	36.5	23.6	0	120	89	0	35	34	34	
2025	11	10	9	42	15	24.4	-1.1	1.082	0.3	0.2	0	36.5	23.6	0	120	89	0	35	34	35	
2025	11	10	9	52	15	25.3	-1.6	1.082	0.5	0.4	0	37.4	24.5	0	122	91	0	35	34	35	
2025	11	10	10	2	15	24.2	-1.5	1.082	0.5	0.4	0	37.8	25.4	0	123	92	0	35	33	35	
2025	11	10	10	12	15	24.6	-0.8	1.082	0.4	0.3	0	37.8	25.4	0	123	92	0	35	33	34	
2025	11	10	10	22	15	25	-0.3	1.083	0.3	0.2	0	37.4	24.9	0	122	91	0	35	33	34	
2025	11	10	10	32	15	24.8	-2	1.082	0.4	0.3	0	37.4	24.9	0	122	92	0	35	34	35	
2025	11	10	10	42	15	25.4	-0.8	1.082	0.3	0.2	0	37.8	25.8	0	123	94	0	35	34	35	
2025	11	10	10	52	15	24.2	-0.9	1.082	0.3	0.2	0	37	24.9	0	121	92	0	35	34	35	
2025	11	10	11	2	15	24	-0.4	1.082	0.4	0.3	0	38.3	26.2	0	124	95	0	35	34	34	
2025	11	10	11	12	15	24.8	-0.4	1.082	0.3	0.2	0	37.4	25.4	0	122	93	0	35	34	35	
2025	11	10	11	22	15	25.4	-1.9	1.082	0.5	0.4	0	38.3	25.8	0	123	94	0	34	34	35	
2025	11	10	11	32	15	25	-0.1	1.082	0.5	0.4	0	38.7	26.7	0	125	96	0	35	34	34	
2025	11	10	11	42	15	23.4	-1.2	1.082	0.4	0.3	0	37.4	25.4	0	122	93	0	35	34	35	
2025	11	10	11	52	15	25.9	-1.6	1.082	0.4	0.3	0	36.5	24.9	0	120	92	0	35	34	35	
2025	11	10	12	2	15	24.7	-1.7	1.082	0.4	0.3	0	36.5	24.5	0	119	91	0	34	34	35	
2025	11	10	12	12	15	26.1	-2.1	1.082	0.4	0.3	0	36.5	24.1	0	120	90	0	35	34	35	
2025	11	10	12	22	15	25.2	-2.1	1.082	0.3	0.2	0	36.5	23.6	0	120	89	0	35	34	34	
2025	11	10	12	32	15	24.1	-1.1	1.083	0.5	0.5	0	36.5	24.5	0	120	90	0	35	33	35	
2025	11	10	12	42	15	25.1	-2.2	1.083	0.3	0.2	0	36.5	24.1	0	119	90	0	34	34	34	
2025	11	10	12	52	15	25.4	-1.7	1.083	0.3	0.2	0	36.5	24.1	0	120	90	0	35	34	35	
2025	11	10	13	2	15	25.2	-1.1	1.082	0.3	0.2	0	37.4	24.5	0	122	91	0	35	34	35	
2025	11	10	13	12	15	26.2	-2.5	1.082	0.4	0.3	0	37	24.5	0	121	91	0	35	34	35	
2025	11	10	13	22	15	25.5	-1.2	1.082	0.5	0.5	0	36.5	24.1	0	120	89	0	35	33	35	
2025	11	10	13	32	15	24.2	-2.5	1.082	0.4	0.3	0	36.5	24.1	0	120	89	0	35	33	35	
2025	11	10	13	42	15	26	-2.5	1.082	0.4	0.3	0	37	24.5	0	120	90	0	34	33	35	
2025	11	10	13	52	15	24.2	-1	1.082	0.4	0.3	0	37	24.1	0	121	90	0	35	34	35	
2025	11	10	14	2	15	24.5	-1.5	1.082	0.3	0.2	0	37.4	24.5	0	122	91	0	35	34	35	
2025	11	10	14	12	15	24.7	-1.7	1.082	0.5	0.4	0	37	24.9	0	121	91	0	35	33	35	
2025	11	10	14	22	15	24.2	-0.7	1.082	0.5	0.4	0	36.5	24.1	0	120	90	0	35	34	35	
2025	11	10	14	32	15	23.8	-0.4	1.082	0.3	0.2	0	36.5	24.5	0	120	90	0	35	33	34	
2025	11	10	14	42	15	24.1	-1.6	1.082	0.4	0.3	0	36.1	24.1	0	119	90	0	35	34	35	
2025	11	10	14	52	15	24.7	-0.6	1.082	0.3	0.2	0	36.5	24.1	0	120	90	0	35	34	34	
2025	11	10	15	2	15	23.9	-2.1	1.081	0.3	0.2	0	36.5	24.1	0	120	90	0	35	34	34	
2025	11	10	15	12	15	24.9	-2.1	1.081	0.4	0.3	0	36.5	23.6	0	120	89	0	35	34	35	
2025	11	10	15	22	15	24.3	-0.7	1.082	0.3	0.2	0	36.1	23.6	0	119	89	0	35	34	35	
2025	11	10	15	32	15	24.5	-1.7	1.081	0.3	0.2	0	36.5	24.1	0	120	90	0	35	34	35	
2025	11	10	15	42	15	24.7	-0.4	1.081	0.3	0.2	0	37	24.1	0	120	90	0	34	34	34	
2025	11	10	15	52	15	24.7	-0.4	1.081	0.5	0.4	0	37	24.1	0	120	90	0	34	34	35	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	10	16	2	15	24.5	-1	1.081	0.3	0.2	0	36.1	23.6	0	119	89	0	35	34	35
2025	11	10	16	12	15	24.5	-0.7	1.081	0.4	0.3	0	35.7	23.6	0	118	88	0	35	33	34
2025	11	10	16	22	15	25.1	-0.5	1.081	0.3	0.2	0	35.7	23.2	0	118	87	0	35	33	35
2025	11	10	16	32	15	24.7	-1.5	1.081	0.3	0.2	0	35.7	22.8	0	118	87	0	35	34	34
2025	11	10	16	42	15	24.4	-1.1	1.08	0.3	0.2	0	35.7	23.2	0	118	87	0	35	33	35
2025	11	10	16	52	15	24.1	-1.2	1.081	0.3	0.2	0	35.7	22.4	0	117	86	0	34	34	35
2025	11	10	17	2	15	24.9	-0.8	1.081	0.4	0.3	0	35.3	21.9	0	117	85	0	35	34	35
2025	11	10	17	12	15	23.7	-0.2	1.08	0.3	0.2	0	35.3	22.4	0	117	85	0	35	33	35
2025	11	10	17	22	15	23.7	-1.8	1.08	0.4	0.3	0	35.3	22.8	0	117	86	0	35	33	34
2025	11	10	17	32	15	24.5	-0.5	1.079	0.4	0.3	0	36.5	24.1	0	120	89	0	35	33	35
2025	11	10	17	42	15	23.7	0	1.079	0.5	0.4	0	35.7	22.8	0	118	87	0	35	34	34
2025	11	10	17	52	15	24.4	0.1	1.079	0.4	0.3	0	36.1	23.2	0	118	87	0	34	33	35
2025	11	10	18	2	15	23.6	-0.8	1.079	0.4	0.3	0	36.5	23.2	0	119	88	0	34	34	35
2025	11	10	18	12	15	24.3	-0.4	1.078	0.3	0.2	0	36.1	23.2	0	119	87	0	35	33	35
2025	11	10	18	22	15	24.6	-0.4	1.078	0.4	0.3	0	36.1	23.2	0	119	88	0	35	34	35
2025	11	10	18	32	15	23.5	-0.5	1.077	0.3	0.2	0	36.1	23.2	0	119	88	0	35	34	34
2025	11	10	18	42	15	24.2	-0.8	1.078	0.4	0.3	0	36.5	23.2	0	120	88	0	35	34	35
2025	11	10	18	52	15	24.2	-1.5	1.078	0.4	0.3	0	37	23.6	0	121	88	0	35	33	35
2025	11	10	19	2	15	24.2	-0.4	1.078	0.3	0.2	0	37	24.5	0	121	89	0	35	32	34
2025	11	10	19	12	15	24.4	-0.9	1.077	0.4	0.3	0	37	24.1	0	121	89	0	35	33	34
2025	11	10	19	22	15	24.3	-1.2	1.077	0.4	0.3	0	37	23.6	0	121	89	0	35	34	35
2025	11	10	19	32	15	24.6	-1.4	1.077	0.3	0.2	0	37	24.1	0	121	89	0	35	33	34
2025	11	10	19	42	15	24.7	-0.1	1.077	0.4	0.3	0	36.5	23.6	0	120	89	0	35	34	35
2025	11	10	19	52	15	25.2	-1.7	1.077	0.5	0.5	0	37	23.6	0	120	88	0	34	33	35
2025	11	10	20	2	15	24.6	-1.6	1.077	0.3	0.2	0	37	23.6	0	121	89	0	35	34	35
2025	11	10	20	12	15	25	-0.9	1.077	0.3	0.2	0	36.5	24.1	0	120	89	0	35	33	34
2025	11	10	20	22	15	24.6	-1.1	1.077	0.4	0.3	0	37.4	24.1	0	122	89	0	35	33	34
2025	11	10	20	32	15	24.2	-1	1.077	0.4	0.3	0	37.4	23.6	0	122	89	0	35	34	35
2025	11	10	20	42	15	25	-1.4	1.076	0.3	0.2	0	37.8	23.6	0	122	89	0	34	34	35
2025	11	10	20	52	15	25.4	-2.6	1.076	0.4	0.3	0	37.8	23.6	0	122	89	0	34	34	34
2025	11	10	21	2	15	24.4	-0.8	1.076	0.5	0.4	0	37.4	23.6	0	122	89	0	35	34	35
2025	11	10	21	12	15	25.6	-1.6	1.076	0.5	0.4	0	37.4	23.6	0	122	89	0	35	34	34
2025	11	10	21	22	15	25.7	-2	1.076	0.4	0.3	0	37	23.6	0	122	89	0	36	34	35
2025	11	10	21	32	15	25.1	0	1.076	0.4	0.3	0	37.4	24.1	0	122	90	0	35	34	34
2025	11	10	21	42	15	26.3	-1.6	1.076	0.4	0.3	0	37.4	23.6	0	122	89	0	35	34	35
2025	11	10	21	52	15	25.3	-1.2	1.076	0.4	0.3	0	38.3	24.5	0	123	90	0	34	33	35
2025	11	10	22	2	15	24.4	-0.3	1.076	0.5	0.4	0	37.8	24.1	0	123	90	0	35	34	34
2025	11	10	22	12	15	24.5	-1.2	1.076	0.3	0.2	0	37.8	24.5	0	123	90	0	35	33	34
2025	11	10	22	22	15	23.8	-1.5	1.075	0.4	0.3	0	37.8	24.1	0	123	90	0	35	34	35
2025	11	10	22	32	15	24.7	-1.9	1.076	0.4	0.3	0	37.4	24.1	0	122	90	0	35	34	34
2025	11	10	22	42	15	24.9	-1.1	1.075	0.4	0.3	0	37.4	24.1	0	122	90	0	35	34	35
2025	11	10	22	52	15	23.8	-1.8	1.075	0.3	0.2	0	37.4	23.6	0	122	89	0	35	34	35
2025	11	10	23	2	15	25.7	-1.7	1.075	0.4	0.3	0	37.4	24.1	0	122	90	0	35	34	35
2025	11	10	23	12	15	26.1	-1.6	1.075	0.4	0.3	0	37.4	24.5	0	122	90	0	35	33	35
2025	11	10	23	22	15	25.9	-2.3	1.075	0.5	0.4	0	37.4	24.1	0	122	89	0	35	33	34
2025	11	10	23	32	15	24.1	-1.4	1.075	0.4	0.3	0	37.4	24.1	0	122	90	0	35	34	35
2025	11	10	23	42	15	26.3	-2	1.075	0.3	0.2	0	37	23.2	0	121	88	0	35	34	34
2025	11	10	23	52	15	26.2	-2.6	1.075	0.3	0.2	0	37.4	23.6	0	122	89	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	11	0	2	15	25.8	-2.2	1.075	0.3	0.2	0	37.4	23.6	0	122	89	0	35	34	35
2025	11	11	0	12	15	24.4	-1.4	1.075	0.4	0.3	0	37.4	24.1	0	122	90	0	35	34	35
2025	11	11	0	22	15	26.3	-2.4	1.075	0.4	0.3	0	37	23.2	0	121	88	0	35	34	35
2025	11	11	0	32	15	25.7	-2.3	1.075	0.3	0.2	0	37	23.2	0	121	88	0	35	34	34
2025	11	11	0	42	15	25.4	-1.3	1.075	0.4	0.3	0	37	23.6	0	121	89	0	35	34	35
2025	11	11	0	52	15	26.6	-3	1.075	0.3	0.2	0	37	23.2	0	121	89	0	35	35	34
2025	11	11	1	2	15	26.9	-2.3	1.074	0.4	0.3	0	37.4	24.1	0	122	90	0	35	34	34
2025	11	11	1	12	15	25.9	-3.1	1.075	0.5	0.4	0	37.8	24.1	0	122	90	0	34	34	35
2025	11	11	1	22	15	26	-3.2	1.074	0.4	0.3	0	37.4	24.1	0	122	90	0	35	34	35
2025	11	11	1	32	15	24.6	-2.3	1.075	0.5	0.4	0	37	24.1	0	122	90	0	36	34	35
2025	11	11	1	42	15	25.7	-2.7	1.075	0.4	0.3	0	38.3	24.5	0	123	91	0	34	34	36
2025	11	11	1	52	15	25.7	-3.3	1.074	0.3	0.2	0	37.4	24.1	0	122	90	0	35	34	35
2025	11	11	2	2	15	24.8	-2.1	1.074	0.5	0.4	0	37.4	24.1	0	122	90	0	35	34	34
2025	11	11	2	12	15	26	-1.9	1.075	0.4	0.3	0	37	23.6	0	121	89	0	35	34	35
2025	11	11	2	22	15	25.9	-2.6	1.074	0.3	0.2	0	37	23.6	0	121	89	0	35	34	35
2025	11	11	2	32	15	25.8	-1.9	1.074	0.5	0.4	0	37	23.6	0	121	89	0	35	34	35
2025	11	11	2	42	15	26.6	-2.5	1.074	0.3	0.2	0	37	23.6	0	121	89	0	35	34	34
2025	11	11	2	52	15	26.5	-3.2	1.074	0.5	0.4	0	37	23.6	0	121	88	0	35	33	34
2025	11	11	3	2	15	26.2	-3.3	1.074	0.5	0.4	0	37	23.6	0	121	89	0	35	34	35
2025	11	11	3	12	15	25.7	-2.4	1.074	0.3	0.2	0	36.5	23.2	0	120	88	0	35	34	34
2025	11	11	3	22	15	26.5	-3.3	1.074	0.3	0.2	0	37	23.2	0	121	88	0	35	34	35
2025	11	11	3	32	15	25.3	-2.5	1.074	0.5	0.4	0	37	23.2	0	121	88	0	35	34	35
2025	11	11	3	42	15	26.9	-3	1.074	0.4	0.3	0	36.5	23.2	0	120	88	0	35	34	35
2025	11	11	3	52	15	26.7	-3.1	1.074	0.3	0.2	0	36.5	23.2	0	120	88	0	35	34	35
2025	11	11	4	2	15	26.5	-2.3	1.074	0.5	0.4	0	36.5	22.8	0	120	87	0	35	34	35
2025	11	11	4	12	15	25.7	-3.1	1.074	0.3	0.2	0	36.5	22.8	0	120	87	0	35	34	35
2025	11	11	4	22	15	26.5	-3.4	1.074	0.4	0.3	0	36.5	22.8	0	120	87	0	35	34	34
2025	11	11	4	32	15	26.2	-2.4	1.074	0.5	0.5	0	36.5	22.8	0	120	87	0	35	34	35
2025	11	11	4	42	15	26.5	-2.9	1.073	0.4	0.3	0	36.5	22.8	0	120	87	0	35	34	35
2025	11	11	4	52	15	25.2	-2.2	1.074	0.5	0.4	0	35.7	22.4	0	119	86	0	36	34	35
2025	11	11	5	2	15	26.6	-3	1.074	0.3	0.2	0	36.1	21.9	0	119	85	0	35	34	34
2025	11	11	5	12	15	25.8	-3.2	1.074	0.3	0.2	0	36.1	21.9	0	119	85	0	35	34	35
2025	11	11	5	22	15	26.1	-2.5	1.073	0.5	0.4	0	36.1	21.9	0	119	85	0	35	34	34
2025	11	11	5	32	15	25.7	-2.6	1.074	0.5	0.4	0	36.5	22.4	0	119	86	0	34	34	35
2025	11	11	5	42	15	26.3	-2.9	1.074	0.3	0.2	0	36.1	22.4	0	119	86	0	35	34	35
2025	11	11	5	52	15	25.3	-2.4	1.074	0.5	0.4	0	36.1	22.4	0	119	86	0	35	34	35
2025	11	11	6	2	15	25.7	-3.4	1.074	0.3	0.2	0	36.1	22.4	0	119	86	0	35	34	34
2025	11	11	6	12	15	26.1	-3.7	1.073	0.5	0.4	0	36.1	21.9	0	119	86	0	35	35	35
2025	11	11	6	22	15	26	-2.2	1.073	0.5	0.4	0	36.1	22.4	0	119	86	0	35	34	34
2025	11	11	6	32	15	25.9	-3.4	1.073	0.4	0.3	0	36.1	22.4	0	119	86	0	35	34	35
2025	11	11	6	42	15	27.2	-3.3	1.074	0.3	0.2	0	35.7	21.9	0	118	85	0	35	34	35
2025	11	11	6	52	15	26.4	-2.4	1.074	0.3	0.2	0	35.7	21.9	0	118	85	0	35	34	35
2025	11	11	7	2	15	26.6	-3	1.073	0.5	0.4	0	35.7	21.9	0	118	85	0	35	34	35
2025	11	11	7	12	15	26.6	-4.3	1.073	0.3	0.2	0	36.1	21.9	0	119	85	0	35	34	35
2025	11	11	7	22	15	26.4	-3.1	1.073	0.4	0.3	0	36.1	21.9	0	119	85	0	35	34	35
2025	11	11	7	32	15	26.5	-3.4	1.073	0.5	0.4	0	36.1	22.4	0	119	85	0	35	33	35
2025	11	11	7	42	15	25.3	-3.3	1.073	0.4	0.3	0	36.1	21.9	0	119	85	0	35	34	35
2025	11	11	7	52	15	26.1	-4.3	1.073	0.5	0.4	0	35.7	21.5	0	118	84	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	11	8	2	15	25.2	-2.5	1.073	0.5	0.4	0	35.7	21.9	0	118	85	0	35	34	35
2025	11	11	8	12	15	25.7	-2.9	1.073	0.4	0.3	0	35.7	21.9	0	118	85	0	35	34	34
2025	11	11	8	22	15	25.8	-3.8	1.073	0.4	0.3	0	35.7	22.4	0	118	85	0	35	33	35
2025	11	11	8	32	15	25.3	-3.4	1.074	0.5	0.4	0	35.7	21.9	0	118	85	0	35	34	34
2025	11	11	8	42	15	25.8	-3	1.073	0.5	0.4	0	35.7	21.5	0	118	84	0	35	34	35
2025	11	11	8	52	15	25.7	-2.6	1.073	0.4	0.3	0	35.3	21.5	0	117	84	0	35	34	34
2025	11	11	9	2	15	25.5	-1.9	1.073	0.4	0.3	0	35.7	21.9	0	118	85	0	35	34	35
2025	11	11	9	12	15	24.9	-2.9	1.073	0.4	0.3	0	35.7	21.9	0	118	85	0	35	34	35
2025	11	11	9	22	15	24.7	-2.5	1.073	0.4	0.3	0	35.7	21.9	0	118	85	0	35	34	34
2025	11	11	9	32	15	24.8	-2.9	1.073	0.3	0.2	0	35.3	21.9	0	117	84	0	35	33	35
2025	11	11	9	42	15	26.1	-2.6	1.073	0.3	0.2	0	35.3	21.1	0	117	83	0	35	34	34
2025	11	11	9	52	15	25.5	-3	1.073	0.4	0.3	0	34.8	21.1	0	116	83	0	35	34	35
2025	11	11	10	2	15	25.4	-2.3	1.073	0.3	0.2	0	34.8	21.1	0	116	83	0	35	34	34
2025	11	11	10	12	15	25.4	-2.8	1.073	0.5	0.4	0	35.3	21.5	0	117	84	0	35	34	35
2025	11	11	10	22	15	25.6	-2.3	1.073	0.4	0.3	0	34.8	21.5	0	116	84	0	35	34	34
2025	11	11	10	32	15	25	-1.4	1.074	0.4	0.3	0	34.8	21.5	0	116	84	0	35	34	35
2025	11	11	10	42	15	24.9	-2.3	1.073	0.5	0.4	0	34.4	21.1	0	115	83	0	35	34	35
2025	11	11	10	52	15	25.3	-2.9	1.073	0.4	0.3	0	34.8	21.5	0	116	83	0	35	33	34
2025	11	11	11	2	15	25	-2.5	1.073	0.4	0.3	0	35.3	21.9	0	117	84	0	35	33	34
2025	11	11	11	12	15	24.4	-2.9	1.073	0.3	0.2	0	35.3	21.9	0	117	85	0	35	34	35
2025	11	11	11	22	15	25.7	-2.5	1.073	0.3	0.2	0	34.8	21.9	0	116	84	0	35	33	34
2025	11	11	11	32	15	24.6	-2.3	1.074	0.5	0.4	0	34.8	21.9	0	116	84	0	35	33	35
2025	11	11	11	42	15	25.5	-2	1.074	0.4	0.3	0	35.3	21.9	0	117	85	0	35	34	34
2025	11	11	11	52	15	25.9	-1.8	1.074	0.4	0.3	0	34.8	21.9	0	117	85	0	36	34	34
2025	11	11	12	2	15	24.3	-2.1	1.074	0.4	0.3	0	35.7	22.8	0	118	86	0	35	33	34
2025	11	11	12	12	15	22.9	0.1	1.074	0.5	0.5	0	35.3	22.4	0	117	86	0	35	34	35
2025	11	11	12	22	15	23.4	-1.3	1.074	0.4	0.3	0	35.7	22.8	0	118	86	0	35	33	34
2025	11	11	12	32	15	23.3	-1.1	1.074	0.4	0.3	0	36.1	22.8	0	119	87	0	35	34	35
2025	11	11	12	42	15	26.1	-1.8	1.073	0.3	0.2	0	35.7	22.4	0	118	86	0	35	34	35
2025	11	11	12	52	15	25.5	-2.2	1.073	0.5	0.4	0	35.7	22.4	0	118	86	0	35	34	35
2025	11	11	13	2	15	25.8	-2.4	1.074	0.4	0.3	0	34.4	22.4	0	116	85	0	36	33	34
2025	11	11	13	12	15	25.5	-1.6	1.074	0.3	0.2	0	34.8	22.4	0	116	85	0	35	33	35
2025	11	11	13	22	15	25.1	-1.5	1.074	0.3	0.2	0	35.7	22.4	0	117	85	0	34	33	35
2025	11	11	13	32	15	23.7	-0.8	1.074	0.3	0.2	0	35.3	21.9	0	117	85	0	35	34	35
2025	11	11	13	42	15	25	-1.2	1.073	0.5	0.4	0	34.8	21.5	0	116	84	0	35	34	35
2025	11	11	13	52	15	24.6	-2.2	1.073	0.5	0.4	0	34.8	21.5	0	116	84	0	35	34	34
2025	11	11	14	2	15	25	-1.8	1.073	0.4	0.3	0	34.4	21.5	0	115	84	0	35	34	34
2025	11	11	14	12	15	25.3	-2.8	1.073	0.5	0.4	0	34.8	22.4	0	116	85	0	35	33	34
2025	11	11	14	22	15	27.2	-2.6	1.073	0.4	0.3	0	35.7	22.4	0	118	86	0	35	34	35
2025	11	11	14	32	15	26.7	-2.7	1.074	0.4	0.3	0	35.3	21.9	0	117	85	0	35	34	35
2025	11	11	14	42	15	25.8	-2.9	1.073	0.3	0.2	0	34.4	21.5	0	115	83	0	35	33	34
2025	11	11	14	52	15	24.6	-2.7	1.073	0.4	0.3	0	34.4	21.1	0	115	83	0	35	34	35
2025	11	11	15	2	15	25.8	-3.4	1.073	0.3	0.2	0	34.4	21.1	0	115	82	0	35	33	35
2025	11	11	15	12	15	25	-2.9	1.073	0.3	0.2	0	34.4	20.6	0	115	82	0	35	34	35
2025	11	11	15	22	15	25.4	-2.5	1.073	0.3	0.2	0	34.4	21.1	0	115	83	0	35	34	34
2025	11	11	15	32	15	23.9	-1.7	1.073	0.4	0.3	0	34.8	21.1	0	116	83	0	35	34	34
2025	11	11	15	42	15	25.8	-3.3	1.073	0.5	0.4	0	34.4	20.6	0	115	82	0	35	34	34
2025	11	11	15	52	15	23.9	-2.4	1.073	0.3	0.2	0	34.4	20.6	0	115	82	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	11	16	2	15	24.7	-2.9	1.073	0.4	0.3	0	34	20.2	0	114	81	0	35	34	34
2025	11	11	16	12	15	25.3	-2	1.073	0.5	0.4	0	34	20.2	0	114	81	0	35	34	35
2025	11	11	16	22	15	26.1	-3.1	1.073	0.3	0.2	0	34	20.6	0	114	81	0	35	33	35
2025	11	11	16	32	15	26.2	-3.4	1.073	0.5	0.4	0	34	20.6	0	114	82	0	35	34	35
2025	11	11	16	42	15	26.3	-3.9	1.073	0.4	0.3	0	34.4	20.2	0	115	81	0	35	34	35
2025	11	11	16	52	15	24.8	-2.9	1.073	0.3	0.2	0	34.4	21.1	0	115	82	0	35	33	35
2025	11	11	17	2	15	26.7	-2.8	1.073	0.3	0.2	0	34.4	20.6	0	115	82	0	35	34	35
2025	11	11	17	12	15	25.8	-3.9	1.073	0.4	0.3	0	34.4	20.6	0	115	82	0	35	34	35
2025	11	11	17	22	15	26.3	-2.3	1.073	0.4	0.3	0	34.4	21.1	0	115	82	0	35	33	35
2025	11	11	17	32	15	25.7	-2.7	1.073	0.4	0.3	0	34.8	21.1	0	116	82	0	35	33	34
2025	11	11	17	42	15	25.6	-3.1	1.073	0.4	0.3	0	34.8	21.5	0	116	83	0	35	33	34
2025	11	11	17	52	15	26.3	-2.5	1.073	0.4	0.3	0	35.3	21.5	0	117	84	0	35	34	34
2025	11	11	18	2	15	26	-3.3	1.073	0.3	0.2	0	35.3	21.5	0	117	84	0	35	34	35
2025	11	11	18	12	15	27.9	-3.8	1.073	0.4	0.3	0	35.3	21.5	0	117	84	0	35	34	35
2025	11	11	18	22	15	24.8	-2.8	1.073	0.4	0.3	0	35.3	21.9	0	118	85	0	36	34	35
2025	11	11	18	32	15	24.5	-2.1	1.073	0.3	0.2	0	36.1	21.9	0	118	85	0	34	34	35
2025	11	11	18	42	15	24.7	-2.9	1.073	0.3	0.2	0	36.1	21.9	0	118	85	0	34	34	34
2025	11	11	18	52	15	25.6	-3.6	1.073	0.4	0.3	0	35.7	21.9	0	118	85	0	35	34	34
2025	11	11	19	2	15	25.2	-2.5	1.073	0.3	0.2	0	35.7	22.4	0	118	86	0	35	34	34
2025	11	11	19	12	15	26.3	-2.9	1.073	0.4	0.3	0	35.7	21.9	0	118	85	0	35	34	35
2025	11	11	19	22	15	25.1	-2.6	1.073	0.4	0.3	0	36.5	21.9	0	119	85	0	34	34	34
2025	11	11	19	32	15	26	-3.5	1.072	0.4	0.3	0	36.1	21.9	0	119	85	0	35	34	34
2025	11	11	19	42	15	26.7	-3.3	1.072	0.3	0.2	0	35.7	21.9	0	118	85	0	35	34	35
2025	11	11	19	52	15	27.3	-2.7	1.073	0.4	0.3	0	35.7	21.9	0	118	85	0	35	34	35
2025	11	11	20	2	15	25.8	-2.4	1.072	0.4	0.3	0	35.7	21.9	0	118	85	0	35	34	35
2025	11	11	20	12	15	25.7	-3.3	1.073	0.4	0.3	0	35.7	21.9	0	118	85	0	35	34	34
2025	11	11	20	22	15	25.3	-3.1	1.073	0.4	0.3	0	35.7	21.9	0	118	85	0	35	34	34
2025	11	11	20	32	15	25.6	-3.1	1.072	0.5	0.4	0	36.1	21.9	0	119	85	0	35	34	36
2025	11	11	20	42	15	25.3	-3.4	1.072	0.3	0.2	0	35.7	21.9	0	118	85	0	35	34	34
2025	11	11	20	52	15	26.4	-3.4	1.072	0.4	0.3	0	35.7	21.9	0	118	85	0	35	34	35
2025	11	11	21	2	15	25.8	-2.5	1.072	0.3	0.2	0	36.1	21.9	0	119	85	0	35	34	35
2025	11	11	21	12	15	26.1	-2.5	1.072	0.4	0.3	0	36.1	22.8	0	119	86	0	35	33	35
2025	11	11	21	22	15	26.6	-2.1	1.072	0.5	0.4	0	36.1	22.8	0	119	86	0	35	33	35
2025	11	11	21	32	15	26.1	-3.1	1.072	0.5	0.4	0	36.1	22.4	0	119	86	0	35	34	34
2025	11	11	21	42	15	25.5	-2.4	1.072	0.3	0.2	0	36.5	22.4	0	120	86	0	35	34	35
2025	11	11	21	52	15	25.4	-3.4	1.072	0.3	0.2	0	36.5	22.4	0	120	86	0	35	34	35
2025	11	11	22	2	15	25.1	-2.9	1.072	0.3	0.2	0	36.5	22.4	0	120	86	0	35	34	35
2025	11	11	22	12	15	25.3	-2.3	1.072	0.3	0.2	0	36.1	22.4	0	120	86	0	36	34	35
2025	11	11	22	22	15	25	-3	1.072	0.4	0.3	0	37.4	23.2	0	122	88	0	35	34	35
2025	11	11	22	32	15	26	-3.2	1.072	0.4	0.3	0	37	22.8	0	121	87	0	35	34	35
2025	11	11	22	42	15	26.1	-2.8	1.072	0.5	0.4	0	36.5	22.4	0	120	86	0	35	34	34
2025	11	11	22	52	15	26.9	-3.3	1.072	0.3	0.2	0	37	23.2	0	121	87	0	35	33	35
2025	11	11	23	2	15	25.7	-3.4	1.072	0.4	0.3	0	37.8	23.6	0	123	89	0	35	34	34
2025	11	11	23	12	15	25.7	-3	1.072	0.4	0.3	0	37	23.2	0	121	87	0	35	33	35
2025	11	11	23	22	15	26.6	-3.7	1.072	0.4	0.3	0	37.8	23.6	0	123	89	0	35	34	35
2025	11	11	23	32	15	24.9	-2.5	1.072	0.4	0.3	0	37.8	23.6	0	123	89	0	35	34	35
2025	11	11	23	42	15	25.5	-2.2	1.072	0.5	0.4	0	37.4	22.8	0	122	87	0	35	34	35
2025	11	11	23	52	15	25.2	-2.7	1.072	0.4	0.3	0	38.3	24.1	0	124	90	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	12	0	2	15	25.7	-3.5	1.072	0.3	0.2	0	37	22.8	0	121	87	0	35	34	35
2025	11	12	0	12	15	24.4	-3.3	1.072	0.3	0.2	0	37	23.2	0	121	87	0	35	33	34
2025	11	12	0	22	15	25.3	-3	1.072	0.5	0.4	0	37	22.8	0	121	87	0	35	34	34
2025	11	12	0	32	15	25.7	-3.2	1.072	0.4	0.3	0	36.5	22.4	0	120	86	0	35	34	35
2025	11	12	0	42	15	25.2	-3.5	1.072	0.3	0.2	0	36.5	22.4	0	120	86	0	35	34	35
2025	11	12	0	52	15	26.3	-2.9	1.072	0.4	0.3	0	37.4	22.4	0	121	86	0	34	34	34
2025	11	12	1	2	15	25.8	-2.2	1.072	0.5	0.4	0	37	22.8	0	121	87	0	35	34	35
2025	11	12	1	12	15	24.9	-3.4	1.072	0.3	0.2	0	36.5	22.4	0	120	86	0	35	34	34
2025	11	12	1	22	15	25	-2.1	1.072	0.4	0.3	0	37	22.8	0	121	87	0	35	34	35
2025	11	12	1	32	15	26.4	-3.9	1.072	0.3	0.2	0	36.5	21.9	0	120	85	0	35	34	35
2025	11	12	1	42	15	25.8	-3.7	1.072	0.3	0.2	0	36.5	22.4	0	120	86	0	35	34	35
2025	11	12	1	52	15	25.3	-3.1	1.072	0.3	0.2	0	36.5	22.8	0	120	86	0	35	33	34
2025	11	12	2	2	15	24.9	-2.3	1.072	0.5	0.4	0	37	22.8	0	121	87	0	35	34	35
2025	11	12	2	12	15	26.9	-4	1.072	0.5	0.4	0	36.5	22.8	0	120	86	0	35	33	34
2025	11	12	2	22	15	27.2	-3.9	1.072	0.4	0.3	0	36.5	21.9	0	119	85	0	34	34	35
2025	11	12	2	32	15	26.2	-4.4	1.072	0.3	0.2	0	36.5	22.4	0	120	86	0	35	34	35
2025	11	12	2	42	15	26	-3.8	1.072	0.4	0.3	0	37.4	22.8	0	121	87	0	34	34	35
2025	11	12	2	52	15	26.2	-3.1	1.072	0.4	0.3	0	36.5	22.4	0	120	86	0	35	34	35
2025	11	12	3	2	15	27.1	-3.5	1.072	0.3	0.2	0	36.1	22.4	0	119	86	0	35	34	34
2025	11	12	3	12	15	25.3	-3.6	1.072	0.5	0.4	0	36.5	22.4	0	120	86	0	35	34	35
2025	11	12	3	22	15	26.3	-1.2	1.072	0.4	0.3	0	37	23.2	0	121	88	0	35	34	35
2025	11	12	3	32	15	26.9	-3.3	1.072	0.5	0.4	0	37.4	23.2	0	121	87	0	34	33	35
2025	11	12	3	42	15	27	-3.4	1.072	0.4	0.3	0	37	23.2	0	121	88	0	35	34	34
2025	11	12	3	52	15	26.5	-2.2	1.072	0.4	0.3	0	36.5	22.4	0	120	86	0	35	34	35
2025	11	12	4	2	15	25.8	-2.5	1.072	0.4	0.3	0	36.1	21.9	0	119	85	0	35	34	34
2025	11	12	4	12	15	27.1	-2.9	1.072	0.4	0.3	0	36.1	22.4	0	119	85	0	35	33	35
2025	11	12	4	22	15	25.1	-2.3	1.072	0.3	0.2	0	36.5	21.9	0	119	85	0	34	34	35
2025	11	12	4	32	15	25.3	-2.9	1.072	0.4	0.3	0	36.1	22.4	0	119	85	0	35	33	35
2025	11	12	4	42	15	25.5	-2.9	1.073	0.5	0.4	0	36.1	22.8	0	119	86	0	35	33	35
2025	11	12	4	52	15	25.8	-3.5	1.073	0.3	0.2	0	37.4	23.2	0	122	88	0	35	34	34
2025	11	12	5	2	15	26.2	-2.5	1.073	0.4	0.3	0	37.8	23.6	0	123	89	0	35	34	34
2025	11	12	5	12	15	26	-2.7	1.073	0.4	0.3	0	36.5	22.4	0	120	86	0	35	34	34
2025	11	12	5	22	15	26.1	-3.4	1.073	0.3	0.2	0	36.5	22.4	0	120	86	0	35	34	35
2025	11	12	5	32	15	27	-2.1	1.073	0.3	0.2	0	36.5	21.9	0	119	85	0	34	34	34
2025	11	12	5	42	15	26.2	-2.2	1.073	0.5	0.4	0	36.1	21.9	0	119	85	0	35	34	34
2025	11	12	5	52	15	25.9	-2.3	1.073	0.4	0.3	0	36.1	21.9	0	119	85	0	35	34	35
2025	11	12	6	2	15	25	-2.7	1.073	0.4	0.3	0	36.1	22.4	0	119	85	0	35	33	34
2025	11	12	6	12	15	25	-2.7	1.073	0.4	0.3	0	36.5	22.8	0	120	86	0	35	33	35
2025	11	12	6	22	15	25.6	-2.5	1.073	0.5	0.4	0	36.1	22.4	0	119	86	0	35	34	35
2025	11	12	6	32	15	25.3	-2.7	1.073	0.3	0.2	0	36.1	21.9	0	119	85	0	35	34	35
2025	11	12	6	42	15	26.2	-2.5	1.073	0.3	0.2	0	36.1	21.9	0	119	85	0	35	34	35
2025	11	12	6	52	15	27.2	-2.8	1.073	0.4	0.3	0	36.1	21.9	0	119	85	0	35	34	34
2025	11	12	7	2	15	26.5	-2.9	1.073	0.3	0.2	0	36.1	22.4	0	119	85	0	35	33	35
2025	11	12	7	12	15	25.7	-2.7	1.073	0.3	0.2	0	35.7	21.9	0	118	85	0	35	34	34
2025	11	12	7	22	15	26.1	-2.8	1.073	0.5	0.4	0	36.1	21.9	0	119	85	0	35	34	35
2025	11	12	7	32	15	26.8	-2.5	1.073	0.4	0.3	0	35.7	21.9	0	119	85	0	36	34	35
2025	11	12	7	42	15	25.5	-1.9	1.073	0.5	0.4	0	36.1	21.9	0	119	85	0	35	34	35
2025	11	12	7	52	15	25.3	-3	1.073	0.4	0.3	0	36.5	21.9	0	119	85	0	34	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	12	8	2	15	26.6	-2.9	1.073	0.4	0.3	0	36.1	21.9	0	119	85	0	35	34	35
2025	11	12	8	12	15	25.9	-3.6	1.074	0.4	0.3	0	35.7	22.4	0	118	85	0	35	33	35
2025	11	12	8	22	15	25.3	-2.3	1.073	0.3	0.2	0	36.1	21.5	0	119	85	0	35	35	35
2025	11	12	8	32	15	26.6	-2.9	1.074	0.4	0.3	0	35.7	21.5	0	118	84	0	35	34	35
2025	11	12	8	42	15	26.6	-3.7	1.074	0.3	0.2	0	35.3	21.1	0	117	83	0	35	34	34
2025	11	12	8	52	15	25.7	-2.7	1.074	0.5	0.4	0	35.7	21.1	0	117	83	0	34	34	34
2025	11	12	9	2	15	27	-3	1.074	0.5	0.5	0	34.8	21.1	0	116	83	0	35	34	34
2025	11	12	9	12	15	26.5	-2.4	1.074	0.3	0.2	0	35.3	21.1	0	117	83	0	35	34	35
2025	11	12	9	22	15	25.8	-3.2	1.074	0.4	0.3	0	34.8	21.1	0	116	83	0	35	34	35
2025	11	12	9	32	15	26.7	-3.3	1.074	0.4	0.3	0	34.8	20.6	0	116	82	0	35	34	35
2025	11	12	9	42	15	25.3	-2.5	1.074	0.4	0.3	0	35.3	21.1	0	117	83	0	35	34	35
2025	11	12	9	52	15	26.4	-3.1	1.074	0.5	0.4	0	34	20.6	0	115	82	0	36	34	35
2025	11	12	10	2	15	26.7	-2.2	1.074	0.5	0.4	0	34.4	20.2	0	114	81	0	34	34	35
2025	11	12	10	12	15	24.7	-3.2	1.075	0.4	0.3	0	34.4	20.6	0	115	82	0	35	34	34
2025	11	12	10	22	15	28	-2.8	1.074	0.3	0.2	0	34.8	20.6	0	116	82	0	35	34	34
2025	11	12	10	32	15	25.3	-2.1	1.075	0.3	0.2	0	34.8	20.6	0	116	82	0	35	34	35
2025	11	12	10	42	15	26.7	-3.7	1.074	0.4	0.3	0	34.8	21.1	0	115	82	0	34	33	35
2025	11	12	10	52	15	26.3	-2.1	1.075	0.4	0.3	0	34.4	20.2	0	115	81	0	35	34	34
2025	11	12	11	2	15	26.8	-3.7	1.075	0.3	0.2	0	34.4	20.6	0	115	82	0	35	34	35
2025	11	12	11	12	15	26.3	-2.6	1.075	0.5	0.4	0	34.4	20.6	0	115	82	0	35	34	34
2025	11	12	11	22	15	27.4	-2.9	1.075	0.3	0.2	0	34	20.2	0	114	81	0	35	34	34
2025	11	12	11	32	15	26.5	-3.3	1.075	0.3	0.2	0	34	20.2	0	114	81	0	35	34	35
2025	11	12	11	42	15	27	-3.3	1.075	0.3	0.2	0	34.8	21.5	0	116	83	0	35	33	34
2025	11	12	11	52	15	26.5	-4	1.075	0.3	0.2	0	34.8	20.6	0	115	82	0	34	34	35
2025	11	12	12	2	15	26.7	-3.3	1.075	0.5	0.4	0	34.4	21.1	0	115	82	0	35	33	35
2025	11	12	12	12	15	26.3	-4.2	1.075	0.5	0.4	0	34.4	20.6	0	115	82	0	35	34	34
2025	11	12	12	22	15	25.8	-3.4	1.075	0.3	0.2	0	34.4	21.5	0	115	83	0	35	33	34
2025	11	12	12	32	15	25.9	-3.7	1.076	0.4	0.3	0	34.4	20.6	0	115	82	0	35	34	35
2025	11	12	12	42	15	26.9	-3.6	1.076	0.4	0.3	0	34.8	21.1	0	115	83	0	34	34	35
2025	11	12	12	52	15	27.5	-3.7	1.076	0.4	0.3	0	35.3	21.9	0	117	85	0	35	34	35
2025	11	12	13	2	15	26.3	-3.3	1.076	0.4	0.3	0	35.3	21.9	0	117	85	0	35	34	35
2025	11	12	13	12	15	26.4	-2.9	1.076	0.4	0.3	0	35.7	22.8	0	118	86	0	35	33	34
2025	11	12	13	22	15	26.4	-3.8	1.076	0.4	0.3	0	35.7	22.4	0	118	86	0	35	34	35
2025	11	12	13	32	15	26.1	-3.3	1.076	0.3	0.2	0	36.1	22.8	0	119	87	0	35	34	35
2025	11	12	13	42	15	25.9	-1.9	1.076	0.5	0.4	0	35.7	22.4	0	118	86	0	35	34	34
2025	11	12	13	52	15	25.5	-2.5	1.076	0.3	0.2	0	35.7	23.2	0	118	87	0	35	33	35
2025	11	12	14	2	15	24.8	-1.7	1.076	0.3	0.2	0	35.7	22.8	0	118	87	0	35	34	35
2025	11	12	14	12	15	25.3	-1.2	1.076	0.3	0.2	0	36.1	22.8	0	118	87	0	34	34	35
2025	11	12	14	22	15	25.6	-2.4	1.076	0.3	0.2	0	35.7	22.8	0	118	87	0	35	34	34
2025	11	12	14	32	15	23.7	-2.1	1.077	0.3	0.2	0	35.7	22.8	0	118	87	0	35	34	34
2025	11	12	14	42	15	24.8	-1.3	1.076	0.4	0.3	0	36.5	23.2	0	119	87	0	34	33	34
2025	11	12	14	52	15	24.8	-1.2	1.076	0.4	0.3	0	36.1	23.6	0	119	88	0	35	33	34
2025	11	12	15	2	15	24.6	-2.5	1.077	0.5	0.4	0	36.1	22.8	0	119	87	0	35	34	35
2025	11	12	15	12	15	24.7	-2.7	1.077	0.4	0.3	0	36.1	23.2	0	119	88	0	35	34	35
2025	11	12	15	22	15	24.6	-2.1	1.077	0.3	0.2	0	35.7	23.2	0	118	87	0	35	33	35
2025	11	12	15	32	15	25.2	-3.7	1.077	0.3	0.2	0	35.7	23.2	0	118	87	0	35	33	34
2025	11	12	15	42	15	25.5	-2.3	1.077	0.5	0.4	0	36.1	22.8	0	118	87	0	34	34	34
2025	11	12	15	52	15	24.7	-2.2	1.077	0.4	0.3	0	35.7	22.8	0	118	87	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	12	16	2	15	25.4	-2.9	1.077	0.4	0.3	0	35.7	22.8	0	118	86	0	35	33	35
2025	11	12	16	12	15	25.1	-1.5	1.077	0.4	0.3	0	35.7	23.2	0	118	87	0	35	33	34
2025	11	12	16	22	15	24.3	-2.5	1.077	0.4	0.3	0	35.7	22.8	0	118	86	0	35	33	35
2025	11	12	16	32	15	24.7	-2.1	1.078	0.4	0.3	0	35.7	22.4	0	118	86	0	35	34	34
2025	11	12	16	42	15	25.1	-2.9	1.077	0.5	0.4	0	35.7	22.4	0	118	85	0	35	33	34
2025	11	12	16	52	15	24.8	-2.9	1.077	0.5	0.5	0	35.3	21.9	0	117	85	0	35	34	34
2025	11	12	17	2	15	25	-2.6	1.077	0.4	0.3	0	34.4	21.5	0	115	83	0	35	33	34
2025	11	12	17	12	15	24.7	-2.1	1.077	0.4	0.3	0	34.8	21.5	0	116	83	0	35	33	35
2025	11	12	17	22	15	26.1	-3.1	1.077	0.4	0.3	0	34.8	21.1	0	115	83	0	34	34	34
2025	11	12	17	32	15	25.5	-2.9	1.078	0.4	0.3	0	34.4	21.1	0	115	83	0	35	34	34
2025	11	12	17	42	15	26	-2.2	1.077	0.5	0.4	0	34.4	20.6	0	115	82	0	35	34	34
2025	11	12	17	52	15	25.2	-1.9	1.077	0.4	0.3	0	34.4	20.6	0	115	82	0	35	34	35
2025	11	12	18	2	15	26.2	-3.3	1.077	0.3	0.2	0	34.4	20.6	0	115	82	0	35	34	35
2025	11	12	18	12	15	26.6	-3.4	1.077	0.4	0.3	0	35.3	21.1	0	117	83	0	35	34	35
2025	11	12	18	22	15	26.4	-2.8	1.077	0.3	0.2	0	34.8	21.1	0	116	83	0	35	34	35
2025	11	12	18	32	15	26.3	-2.1	1.077	0.4	0.3	0	35.7	21.1	0	117	83	0	34	34	34
2025	11	12	18	42	15	27	-3.2	1.077	0.3	0.2	0	35.3	21.1	0	117	83	0	35	34	34
2025	11	12	18	52	15	26.1	-2.6	1.077	0.3	0.2	0	35.3	21.5	0	117	84	0	35	34	34
2025	11	12	19	2	15	25.5	-2.8	1.077	0.3	0.2	0	35.3	21.5	0	117	84	0	35	34	35
2025	11	12	19	12	15	25.5	-2	1.078	0.3	0.2	0	35.7	21.5	0	117	84	0	34	34	34
2025	11	12	19	22	15	26.1	-2.1	1.078	0.4	0.3	0	35.3	21.9	0	117	84	0	35	33	34
2025	11	12	19	32	15	25.2	-2.4	1.077	0.5	0.4	0	35.3	21.5	0	117	84	0	35	34	34
2025	11	12	19	42	15	24.8	-1.5	1.077	0.3	0.2	0	35.7	21.5	0	117	84	0	34	34	34
2025	11	12	19	52	15	25.9	-2.5	1.078	0.4	0.3	0	35.3	21.9	0	117	84	0	35	33	34
2025	11	12	20	2	15	25.9	-2.9	1.078	0.3	0.2	0	35.7	21.5	0	118	84	0	35	34	34
2025	11	12	20	12	15	27.8	-3.7	1.079	0.3	0.2	0	35.7	21.5	0	117	84	0	34	34	34
2025	11	12	20	22	15	27.2	-3.3	1.079	0.3	0.2	0	35.3	21.5	0	117	84	0	35	34	35
2025	11	12	20	32	15	26.8	-3	1.08	0.4	0.3	0	36.1	21.5	0	118	84	0	34	34	34
2025	11	12	20	42	15	27.5	-3.7	1.081	0.4	0.3	0	35.3	21.1	0	117	83	0	35	34	34
2025	11	12	20	52	15	27	-4.3	1.081	0.5	0.4	0	35.3	21.1	0	117	83	0	35	34	35
2025	11	12	21	2	15	26.3	-3.2	1.081	0.5	0.4	0	35.3	21.5	0	117	84	0	35	34	35
2025	11	12	21	12	15	25.9	-3.1	1.08	0.4	0.3	0	35.7	21.9	0	118	84	0	35	33	34
2025	11	12	21	22	15	24.9	-3.5	1.081	0.3	0.2	0	35.3	21.5	0	117	84	0	35	34	34
2025	11	12	21	32	15	27.6	-2.5	1.081	0.3	0.2	0	37.4	22.4	0	122	86	0	35	34	35
2025	11	12	21	42	15	26.7	-2.7	1.081	0.4	0.3	0	37.4	22.4	0	122	86	0	35	34	34
2025	11	12	21	52	15	26.5	-2.9	1.082	0.4	0.3	0	37.4	22.4	0	122	86	0	35	34	34
2025	11	12	22	2	15	26.3	-3.3	1.081	0.3	0.2	0	37.8	22.8	0	123	87	0	35	34	34
2025	11	12	22	12	15	26.8	-3.5	1.081	0.4	0.3	0	37.8	22.8	0	124	87	0	36	34	34
2025	11	12	22	22	15	27.1	-2.3	1.082	0.3	0.2	0	37.8	22.8	0	123	87	0	35	34	35
2025	11	12	22	32	15	25.3	-3.3	1.081	0.3	0.2	0	38.7	22.8	0	124	87	0	34	34	34
2025	11	12	22	42	15	27.6	-3.5	1.082	0.5	0.4	0	37.8	22.8	0	123	87	0	35	34	35
2025	11	12	22	52	15	26.2	-2.5	1.082	0.4	0.3	0	37.8	22.8	0	123	87	0	35	34	34
2025	11	12	23	2	15	26.4	-3.1	1.082	0.6	0.5	0	38.3	22.8	0	124	87	0	35	34	35
2025	11	12	23	12	15	26.2	-2.1	1.082	0.4	0.3	0	37.8	22.8	0	123	87	0	35	34	35
2025	11	12	23	22	15	26.1	-2.9	1.082	0.5	0.4	0	37.8	22.8	0	123	87	0	35	34	35
2025	11	12	23	32	15	25.8	-2.3	1.082	0.4	0.3	0	37.8	22.8	0	123	86	0	35	33	35
2025	11	12	23	42	15	26.7	-3.2	1.082	0.3	0.2	0	38.3	22.8	0	124	87	0	35	34	34
2025	11	12	23	52	15	27.1	-3.1	1.082	0.4	0.3	0	38.3	22.8	0	124	87	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	13	0	2	15	25.8	-2.8	1.082	0.5	0.4	0	38.7	23.2	0	124	88	0	34	34	35
2025	11	13	0	12	15	25.6	-1.8	1.081	0.3	0.2	0	38.7	23.2	0	124	88	0	34	34	34
2025	11	13	0	22	15	25.2	-2.5	1.081	0.5	0.4	0	38.3	23.2	0	124	88	0	35	34	34
2025	11	13	0	32	15	26.1	-2.1	1.08	0.4	0.3	0	38.3	23.2	0	124	88	0	35	34	34
2025	11	13	0	42	15	26.4	-2.1	1.081	0.4	0.3	0	38.3	22.8	0	124	87	0	35	34	35
2025	11	13	0	52	15	26.7	-2.5	1.081	0.3	0.2	0	37.8	22.8	0	123	87	0	35	34	34
2025	11	13	1	2	15	25	-2.9	1.081	0.4	0.3	0	37.8	22.8	0	123	87	0	35	34	34
2025	11	13	1	12	15	26.1	-2	1.08	0.3	0.2	0	37.8	22.8	0	123	87	0	35	34	34
2025	11	13	1	22	15	25.5	-3.2	1.081	0.3	0.2	0	37.8	22.8	0	123	87	0	35	34	35
2025	11	13	1	32	15	26.1	-2.8	1.082	0.5	0.4	0	37.8	22.8	0	123	87	0	35	34	35
2025	11	13	1	42	15	24	-2.8	1.081	0.5	0.4	0	37.8	22.8	0	123	87	0	35	34	34
2025	11	13	1	52	15	26.3	-2.8	1.083	0.4	0.3	0	37.4	22.8	0	122	86	0	35	33	34
2025	11	13	2	2	15	27.2	-2.9	1.083	0.5	0.4	0	37.8	22.8	0	123	87	0	35	34	34
2025	11	13	2	12	15	26.4	-2.6	1.083	0.4	0.3	0	37.8	22.4	0	123	86	0	35	34	34
2025	11	13	2	22	15	26	-2.4	1.083	0.3	0.2	0	37.4	22.4	0	122	86	0	35	34	35
2025	11	13	2	32	15	25.9	-3.1	1.083	0.4	0.3	0	37.4	22.8	0	122	86	0	35	33	35
2025	11	13	2	42	15	27	-2.7	1.083	0.4	0.3	0	37.8	22.8	0	123	87	0	35	34	34
2025	11	13	2	52	15	25.4	-2.1	1.082	0.3	0.2	0	38.7	23.2	0	124	88	0	34	34	34
2025	11	13	3	2	15	25.8	-2.5	1.082	0.4	0.3	0	37.4	22.4	0	122	86	0	35	34	34
2025	11	13	3	12	15	25.4	-1.7	1.082	0.5	0.5	0	37.4	22.4	0	122	86	0	35	34	34
2025	11	13	3	22	15	25.3	-2.6	1.082	0.4	0.3	0	37.4	22.4	0	122	85	0	35	33	35
2025	11	13	3	32	15	26.6	-2.9	1.084	0.4	0.3	0	37.4	21.9	0	122	84	0	35	33	34
2025	11	13	3	42	15	25.9	-2.7	1.084	0.3	0.2	0	37.4	21.9	0	122	85	0	35	34	35
2025	11	13	3	52	15	25.9	-2.9	1.084	0.3	0.2	0	37.4	22.4	0	122	85	0	35	33	34
2025	11	13	4	2	15	26.5	-2.5	1.084	0.3	0.2	0	37.4	22.4	0	122	85	0	35	33	35
2025	11	13	4	12	15	26	-2.2	1.084	0.3	0.2	0	37.4	21.9	0	122	85	0	35	34	35
2025	11	13	4	22	15	27.1	-3.3	1.084	0.4	0.3	0	37.4	21.9	0	122	85	0	35	34	35
2025	11	13	4	32	15	26.4	-2.6	1.084	0.4	0.3	0	37.4	21.9	0	122	85	0	35	34	34
2025	11	13	4	42	15	26.4	-2.9	1.084	0.5	0.4	0	37.8	21.9	0	122	85	0	34	34	34
2025	11	13	4	52	15	27.1	-2.9	1.084	0.3	0.2	0	37	21.9	0	121	85	0	35	34	34
2025	11	13	5	2	15	26.7	-3.8	1.084	0.5	0.5	0	37.4	22.4	0	122	85	0	35	33	34
2025	11	13	5	12	15	26.2	-3.2	1.084	0.3	0.2	0	37.4	21.9	0	122	85	0	35	34	34
2025	11	13	5	22	15	26.7	-3	1.084	0.5	0.4	0	37.4	21.9	0	122	85	0	35	34	35
2025	11	13	5	32	15	26.7	-2.6	1.084	0.3	0.2	0	37.4	21.9	0	122	85	0	35	34	34
2025	11	13	5	42	15	25.2	-2.9	1.084	0.4	0.3	0	37.4	21.9	0	122	85	0	35	34	35
2025	11	13	5	52	15	25.9	-2.8	1.084	0.3	0.2	0	37.4	21.9	0	122	85	0	35	34	34
2025	11	13	6	2	15	27.7	-2.8	1.084	0.4	0.3	0	37.4	22.4	0	122	85	0	35	33	34
2025	11	13	6	12	15	25.9	-2.4	1.084	0.4	0.3	0	37.4	22.4	0	122	86	0	35	34	35
2025	11	13	6	22	15	26.2	-2.4	1.084	0.5	0.4	0	37.4	22.4	0	122	85	0	35	33	35
2025	11	13	6	32	15	27.5	-3	1.084	0.3	0.2	0	37.8	22.4	0	122	85	0	34	33	34
2025	11	13	6	42	15	27.6	-2.1	1.084	0.4	0.3	0	37.4	21.9	0	122	85	0	35	34	34
2025	11	13	6	52	15	25.9	-2	1.084	0.5	0.4	0	37.4	22.4	0	122	85	0	35	33	35
2025	11	13	7	2	15	26.3	-2.1	1.085	0.5	0.5	0	37	21.9	0	121	85	0	35	34	34
2025	11	13	7	12	15	26.2	-2.7	1.085	0.4	0.3	0	37.4	21.9	0	122	85	0	35	34	34
2025	11	13	7	22	15	25.9	-2	1.085	0.4	0.3	0	37.4	21.9	0	122	85	0	35	34	35
2025	11	13	7	32	15	25.6	-2.5	1.084	0.5	0.4	0	37.8	22.8	0	123	86	0	35	33	35
2025	11	13	7	42	15	26.7	-2.5	1.085	0.5	0.4	0	37	22.4	0	121	85	0	35	33	34
2025	11	13	7	52	15	26.7	-1.9	1.084	0.4	0.3	0	37	22.4	0	121	85	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	13	8	2	15	25.4	-3	1.084	0.4	0.3	0	37.4	22.4	0	122	86	0	35	34	34
2025	11	13	8	12	15	25.6	-1.7	1.084	0.4	0.3	0	37.4	22.8	0	122	86	0	35	33	35
2025	11	13	8	22	15	26.4	-1.8	1.084	0.4	0.3	0	37	22.4	0	121	85	0	35	33	35
2025	11	13	8	32	15	25.9	-2.4	1.084	0.3	0.2	0	37	22.4	0	121	86	0	35	34	34
2025	11	13	8	42	15	25	-1	1.083	0.3	0.2	0	37	22.8	0	121	86	0	35	33	34
2025	11	13	8	52	15	25.6	-1.6	1.084	0.4	0.3	0	37	22.4	0	121	86	0	35	34	34
2025	11	13	9	2	15	26.5	-2.2	1.085	0.3	0.2	0	37	22.4	0	120	85	0	34	33	35
2025	11	13	9	12	15	25.5	-2	1.085	0.5	0.5	0	36.5	22.4	0	120	85	0	35	33	34
2025	11	13	9	22	15	25.5	-1.5	1.085	0.5	0.4	0	36.5	22.4	0	120	85	0	35	33	34
2025	11	13	9	32	15	26.5	-2.6	1.085	0.4	0.3	0	37	21.9	0	120	85	0	34	34	34
2025	11	13	9	42	15	23.5	-0.4	1.085	0.5	0.4	0	37.4	22.8	0	121	87	0	34	34	35
2025	11	13	9	52	15	24.8	-1.3	1.083	0.4	0.3	0	38.7	24.5	0	125	91	0	35	34	34
2025	11	13	10	2	15	25.2	-2.1	1.084	0.3	0.2	0	38.7	24.1	0	124	89	0	34	33	35
2025	11	13	10	12	15	24.8	-2.4	1.084	0.3	0.2	0	40	24.9	0	128	92	0	35	34	35
2025	11	13	10	22	15	25.7	-2.1	1.084	0.5	0.5	0	40	25.8	0	128	93	0	35	33	34
2025	11	13	10	32	15	26.2	-2.2	1.084	0.3	0.2	0	40.4	25.4	0	129	93	0	35	34	35
2025	11	13	10	42	15	25.4	-2.2	1.085	0.3	0.2	0	40.4	25.4	0	128	93	0	34	34	35
2025	11	13	10	52	15	25.2	-1.4	1.085	0.3	0.2	0	40.4	24.9	0	129	92	0	35	34	34
2025	11	13	11	2	15	24.8	-2.3	1.086	0.4	0.3	0	40.9	26.2	0	130	95	0	35	34	34
2025	11	13	11	12	15	25.7	-2.1	1.085	0.5	0.4	0	40.9	26.7	0	130	96	0	35	34	35
2025	11	13	11	22	15	26.2	-2.4	1.084	0.5	0.5	0	40.9	26.2	0	130	94	0	35	33	34
2025	11	13	11	32	15	25.4	-2.4	1.084	0.5	0.4	0	41.7	28	0	132	98	0	35	33	34
2025	11	13	11	42	15	24.9	-1.9	1.084	0.3	0.2	0	42.1	27.5	0	132	98	0	34	34	35
2025	11	13	11	52	15	26.1	-1.7	1.085	0.3	0.2	0	40.9	26.7	0	130	96	0	35	34	34
2025	11	13	12	2	15	25.5	-1.8	1.085	0.3	0.2	0	41.7	28	0	132	98	0	35	33	35
2025	11	13	12	12	15	26	-2.1	1.084	0.3	0.2	0	43	28	0	134	99	0	34	34	35
2025	11	13	12	22	15	25	-1.7	1.085	0.3	0.2	0	41.3	27.1	0	131	96	0	35	33	34
2025	11	13	12	32	15	25.3	-1.7	1.086	0.3	0.2	0	39.1	24.5	0	126	91	0	35	34	35
2025	11	13	12	42	15	24.7	-2.5	1.085	0.4	0.3	0	39.1	24.1	0	125	90	0	34	34	35
2025	11	13	12	52	15	24.8	-1.3	1.085	0.3	0.2	0	38.7	24.1	0	125	90	0	35	34	34
2025	11	13	13	2	15	24.9	-1.4	1.085	0.4	0.3	0	40	25.4	0	128	93	0	35	34	35
2025	11	13	13	12	15	27	-2.4	1.084	0.4	0.3	0	42.1	27.1	0	132	96	0	34	33	34
2025	11	13	13	22	15	24.4	-1.5	1.085	0.3	0.2	0	41.3	27.1	0	131	96	0	35	33	35
2025	11	13	13	32	15	25.7	-1.9	1.085	0.4	0.3	0	42.6	27.5	0	134	98	0	35	34	34
2025	11	13	13	42	15	25.7	-2.5	1.084	0.4	0.3	0	41.7	27.5	0	132	97	0	35	33	34
2025	11	13	13	52	15	24.2	-1.8	1.085	0.3	0.2	0	42.1	27.5	0	133	97	0	35	33	34
2025	11	13	14	2	15	25.3	-0.8	1.083	0.4	0.3	0	42.1	27.1	0	132	96	0	34	33	35
2025	11	13	14	12	15	25.2	-1.2	1.084	0.4	0.3	0	42.1	27.5	0	133	97	0	35	33	34
2025	11	13	14	22	15	26	-2	1.086	0.3	0.2	0	42.1	27.1	0	133	97	0	35	34	35
2025	11	13	14	32	15	24.8	-2	1.086	0.3	0.2	0	40.9	25.8	0	130	94	0	35	34	35
2025	11	13	14	42	15	22.9	-0.8	1.086	0.4	0.3	0	40.4	18.5	0	129	77	0	35	34	35
2025	11	13	14	52	15	22.7	-0.4	1.087	0.4	0.3	0	40	16.3	0	128	72	0	35	34	35
2025	11	13	15	2	15	25.6	-2.5	1.084	0.3	0.2	0	40.4	25.4	0	129	93	0	35	34	35
2025	11	13	15	12	15	25.2	-2.5	1.086	0.3	0.2	0	38.7	24.1	0	125	90	0	35	34	34
2025	11	13	15	22	15	26.1	-2.1	1.086	0.4	0.3	0	38.3	23.2	0	124	88	0	35	34	34
2025	11	13	15	32	15	25.3	-2.4	1.084	0.5	0.5	0	38.3	23.2	0	124	88	0	35	34	34
2025	11	13	15	42	15	24.7	-2.1	1.085	0.4	0.3	0	38.3	23.6	0	124	89	0	35	34	34
2025	11	13	15	52	15	24.9	-2.2	1.084	0.3	0.2	0	38.7	24.1	0	125	90	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	13	16	2	15	25.8	-1.7	1.082	0.3	0.2	0	38.3	22.8	0	124	87	0	35	34	34
2025	11	13	16	12	15	25.6	-1.6	1.085	0.4	0.3	0	37.4	23.2	0	122	87	0	35	33	35
2025	11	13	16	22	15	25.8	-2.6	1.085	0.3	0.2	0	37.8	23.2	0	123	87	0	35	33	34
2025	11	13	16	32	15	25.7	-2.2	1.085	0.3	0.2	0	37.8	23.2	0	122	87	0	34	33	34
2025	11	13	16	42	15	25.2	-2.1	1.084	0.4	0.3	0	37.4	22.4	0	122	86	0	35	34	34
2025	11	13	16	52	15	25.1	-2.1	1.085	0.4	0.3	0	37.4	21.9	0	121	85	0	34	34	34
2025	11	13	17	2	15	26.2	-1.8	1.085	0.3	0.2	0	36.5	22.4	0	120	85	0	35	33	35
2025	11	13	17	12	15	26.1	-2.2	1.085	0.5	0.4	0	37.8	22.8	0	123	87	0	35	34	34
2025	11	13	17	22	15	25.5	-1.8	1.084	0.3	0.2	0	37	21.9	0	121	85	0	35	34	34
2025	11	13	17	32	15	25.6	-2.4	1.085	0.3	0.2	0	36.5	21.9	0	120	84	0	35	33	35
2025	11	13	17	42	15	25.6	-1.4	1.085	0.3	0.2	0	36.5	21.9	0	120	84	0	35	33	35
2025	11	13	17	52	15	26.1	-2.2	1.084	0.4	0.3	0	37	22.4	0	121	85	0	35	33	34
2025	11	13	18	2	15	25.3	-1.7	1.085	0.4	0.3	0	36.5	21.9	0	120	85	0	35	34	35
2025	11	13	18	12	15	25	-2.5	1.085	0.4	0.3	0	37.4	22.4	0	122	86	0	35	34	34
2025	11	13	18	22	15	25.6	-1.4	1.084	0.4	0.3	0	37.8	23.2	0	123	87	0	35	33	35
2025	11	13	18	32	15	25.4	-1.9	1.084	0.4	0.3	0	37.8	23.2	0	123	88	0	35	34	34
2025	11	13	18	42	15	26.3	-2	1.085	0.3	0.2	0	37.8	22.8	0	122	87	0	34	34	35
2025	11	13	18	52	15	26.6	-2.9	1.085	0.3	0.2	0	37.8	22.8	0	122	87	0	34	34	35
2025	11	13	19	2	15	25.2	-2	1.085	0.4	0.3	0	37.4	22.8	0	122	87	0	35	34	34
2025	11	13	19	12	15	26.1	-2.5	1.084	0.4	0.3	0	38.3	23.2	0	123	87	0	34	33	34
2025	11	13	19	22	15	25.9	-1.6	1.084	0.3	0.2	0	37.8	23.2	0	123	88	0	35	34	34
2025	11	13	19	32	15	25.8	-1.2	1.085	0.4	0.3	0	37.4	22.4	0	122	86	0	35	34	35
2025	11	13	19	42	15	25.5	-1.5	1.084	0.5	0.4	0	37.4	22.8	0	122	87	0	35	34	35
2025	11	13	19	52	15	24.8	-2.2	1.084	0.4	0.3	0	37.4	22.4	0	122	86	0	35	34	34
2025	11	13	20	2	15	25.6	-2.2	1.084	0.3	0.2	0	37.4	22.4	0	122	86	0	35	34	34
2025	11	13	20	12	15	24.6	-3	1.084	0.3	0.2	0	37.8	22.4	0	122	86	0	34	34	34
2025	11	13	20	22	15	25.2	-1.5	1.084	0.6	0.5	0	37.4	21.9	0	122	85	0	35	34	34
2025	11	13	20	32	15	25.6	-3	1.085	0.3	0.2	0	37.4	22.4	0	122	86	0	35	34	35
2025	11	13	20	42	15	24.9	-2.2	1.085	0.3	0.2	0	37.8	22.8	0	122	86	0	34	33	35
2025	11	13	20	52	15	25.5	-2.5	1.084	0.3	0.2	0	37.4	22.8	0	122	87	0	35	34	35
2025	11	13	21	2	15	25.9	-1.4	1.084	0.3	0.2	0	37.4	22.4	0	121	86	0	34	34	34
2025	11	13	21	12	15	25.6	-1.9	1.085	0.5	0.4	0	36.5	21.9	0	120	84	0	35	33	35
2025	11	13	21	22	15	25.2	-2.6	1.085	0.3	0.2	0	37	21.9	0	121	85	0	35	34	34
2025	11	13	21	32	15	25.1	-1.6	1.084	0.3	0.2	0	37.8	23.2	0	122	87	0	34	33	34
2025	11	13	21	42	15	25.2	-0.8	1.085	0.3	0.2	0	37.8	22.8	0	122	87	0	34	34	34
2025	11	13	21	52	15	25.8	-2	1.084	0.3	0.2	0	37.8	23.2	0	123	88	0	35	34	35
2025	11	13	22	2	15	25.9	-2.2	1.084	0.4	0.3	0	38.3	23.6	0	124	89	0	35	34	34
2025	11	13	22	12	15	24.4	-1.1	1.084	0.3	0.2	0	39.1	24.1	0	126	90	0	35	34	35
2025	11	13	22	22	15	25.5	-0.7	1.086	0.3	0.2	0	38.7	24.1	0	125	89	0	35	33	34
2025	11	13	22	32	15	26.8	-2.3	1.084	0.3	0.2	0	38.7	23.6	0	124	88	0	34	33	34
2025	11	13	22	42	15	24.6	-1.6	1.086	0.3	0.2	0	38.3	24.1	0	124	89	0	35	33	34
2025	11	13	22	52	15	24.8	-2.2	1.085	0.4	0.3	0	38.7	23.6	0	124	88	0	34	33	34
2025	11	13	23	2	15	25.3	-1.9	1.085	0.4	0.3	0	37.8	23.6	0	123	88	0	35	33	34
2025	11	13	23	12	15	26	-2	1.086	0.4	0.3	0	37.8	22.8	0	123	87	0	35	34	35
2025	11	13	23	22	15	24.4	-3.1	1.084	0.4	0.3	0	36.5	23.6	0	119	88	0	34	33	35
2025	11	13	23	32	15	25.3	-1.7	1.086	0.5	0.4	0	37.8	23.2	0	123	87	0	35	33	35
2025	11	13	23	42	15	24.7	-2.3	1.086	0.3	0.2	0	37.4	22.8	0	122	87	0	35	34	34
2025	11	13	23	52	15	25.2	-1.2	1.086	0.5	0.4	0	37.4	22.8	0	122	87	0	35	34	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	14	0	2	15	24.4	-1.1	1.085	0.4	0.3	0	37.8	23.2	0	122	87	0	34	33	34
2025	11	14	0	12	15	25.7	-1.1	1.085	0.5	0.5	0	37.8	23.2	0	123	87	0	35	33	35
2025	11	14	0	22	15	23.2	-1.2	1.087	0.4	0.3	0	37.8	23.2	0	123	88	0	35	34	34
2025	11	14	0	32	15	24.9	-1.6	1.085	0.4	0.3	0	37.8	23.2	0	123	88	0	35	34	35
2025	11	14	0	42	15	24.7	-1.7	1.085	0.3	0.2	0	37.8	23.6	0	123	88	0	35	33	35
2025	11	14	0	52	15	26.6	-1.7	1.087	0.3	0.2	0	38.3	23.2	0	123	87	0	34	33	34
2025	11	14	1	2	15	24.3	-1.4	1.086	0.4	0.3	0	37.4	22.8	0	122	87	0	35	34	35
2025	11	14	1	12	15	24.5	-2.5	1.085	0.4	0.3	0	37.4	22.8	0	122	87	0	35	34	34
2025	11	14	1	22	15	24.7	-2	1.085	0.4	0.3	0	37.8	22.8	0	122	87	0	34	34	35
2025	11	14	1	32	15	25.4	-2.1	1.086	0.3	0.2	0	37.8	22.4	0	122	86	0	34	34	35
2025	11	14	1	42	15	24.6	-1.3	1.086	0.5	0.4	0	38.3	23.2	0	123	87	0	34	33	34
2025	11	14	1	52	15	25.1	-2.1	1.086	0.3	0.2	0	37.8	23.2	0	123	87	0	35	33	34
2025	11	14	2	2	15	25.7	-2.8	1.087	0.3	0.2	0	38.3	23.2	0	123	87	0	34	33	34
2025	11	14	2	12	15	24.6	-1.9	1.086	0.5	0.4	0	38.3	23.2	0	123	87	0	34	33	34
2025	11	14	2	22	15	24.8	-1.9	1.085	0.3	0.2	0	38.3	23.2	0	123	88	0	34	34	35
2025	11	14	2	32	15	24.9	-2.4	1.087	0.5	0.4	0	37.8	23.6	0	123	88	0	35	33	34
2025	11	14	2	42	15	23.8	-1.6	1.086	0.3	0.2	0	38.7	24.1	0	125	89	0	35	33	34
2025	11	14	2	52	15	25.3	-1.9	1.086	0.5	0.4	0	39.1	24.1	0	126	90	0	35	34	34
2025	11	14	3	2	15	24.2	-1.7	1.086	0.3	0.2	0	38.7	23.6	0	125	89	0	35	34	35
2025	11	14	3	12	15	25.3	-1.6	1.086	0.5	0.5	0	39.1	24.1	0	125	89	0	34	33	34
2025	11	14	3	22	15	26.2	-1	1.085	0.4	0.3	0	38.7	23.6	0	124	89	0	34	34	34
2025	11	14	3	32	15	25.9	-0.8	1.084	0.3	0.2	0	39.1	24.1	0	125	89	0	34	33	35
2025	11	14	3	42	15	25.7	-2.4	1.086	0.3	0.2	0	38.3	23.2	0	124	88	0	35	34	34
2025	11	14	3	52	15	25.5	-2.3	1.086	0.4	0.3	0	38.3	23.6	0	123	88	0	34	33	35
2025	11	14	4	2	15	24.5	-2.5	1.087	0.4	0.3	0	37	23.2	0	121	87	0	35	33	34
2025	11	14	4	12	15	26.2	-2.3	1.086	0.4	0.3	0	38.3	22.8	0	124	87	0	35	34	35
2025	11	14	4	22	15	26.6	-1.6	1.087	0.3	0.2	0	38.7	22.8	0	124	87	0	34	34	34
2025	11	14	4	32	15	26.1	-2.1	1.087	0.4	0.3	0	38.3	23.2	0	124	87	0	35	33	35
2025	11	14	4	42	15	24.9	-1.4	1.086	0.4	0.3	0	38.3	22.8	0	124	87	0	35	34	35
2025	11	14	4	52	15	25.5	-1.8	1.086	0.5	0.4	0	38.7	23.2	0	125	88	0	35	34	34
2025	11	14	5	2	15	24.5	-2.1	1.086	0.4	0.3	0	39.1	23.6	0	126	89	0	35	34	34
2025	11	14	5	12	15	26.4	-2.7	1.084	0.3	0.2	0	39.1	24.1	0	126	89	0	35	33	34
2025	11	14	5	22	15	24.6	-0.9	1.085	0.4	0.3	0	39.1	23.2	0	125	88	0	34	34	34
2025	11	14	5	32	15	24.8	-2.6	1.086	0.3	0.2	0	38.7	23.6	0	125	88	0	35	33	35
2025	11	14	5	42	15	25.4	-1.3	1.085	0.3	0.2	0	38.7	23.2	0	125	88	0	35	34	35
2025	11	14	5	52	15	25.2	-1.8	1.086	0.5	0.4	0	39.1	23.2	0	125	88	0	34	34	34
2025	11	14	6	2	15	25.4	-3	1.086	0.3	0.2	0	38.7	22.8	0	125	87	0	35	34	35
2025	11	14	6	12	15	26.5	-2.5	1.087	0.5	0.4	0	38.3	22.8	0	124	87	0	35	34	34
2025	11	14	6	22	15	25.5	-2.1	1.088	0.3	0.2	0	38.3	21.9	0	124	86	0	35	35	35
2025	11	14	6	32	15	25.5	-2.6	1.087	0.3	0.2	0	38.3	22.4	0	124	86	0	35	34	35
2025	11	14	6	42	15	25.4	-2.7	1.087	0.3	0.2	0	38.7	21.9	0	124	86	0	34	35	35
2025	11	14	6	52	15	26.6	-2.7	1.087	0.4	0.3	0	38.3	22.4	0	124	86	0	35	34	34
2025	11	14	7	2	15	24.9	-2.6	1.088	0.3	0.2	0	38.3	22.8	0	124	86	0	35	33	35
2025	11	14	7	12	15	26.4	-2.2	1.087	0.4	0.3	0	37.8	22.4	0	123	86	0	35	34	35
2025	11	14	7	22	15	25.8	-1.6	1.087	0.3	0.2	0	38.3	22.4	0	123	86	0	34	34	34
2025	11	14	7	32	15	25	-2.3	1.087	0.3	0.2	0	38.3	22.4	0	123	86	0	34	34	35
2025	11	14	7	42	15	25.4	-1.3	1.088	0.3	0.2	0	37.8	22.4	0	123	86	0	35	34	34
2025	11	14	7	52	15	26	-2.6	1.088	0.5	0.4	0	37.8	21.9	0	123	85	0	35	34	34

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	11	14	8	2	15	26.2	-3.3	1.087	0.5	0.5	0	37.4	21.9	0	122	85	0	35	34	33	
2025	11	14	8	12	15	25.2	-2.1	1.087	0.3	0.2	0	37.4	21.9	0	122	85	0	35	34	35	
2025	11	14	8	22	15	25.8	-2.4	1.088	0.3	0.2	0	37.4	21.9	0	122	84	0	35	33	34	
2025	11	14	8	32	15	25.2	-1.8	1.087	0.3	0.2	0	37.4	21.9	0	121	84	0	34	33	35	
2025	11	14	8	42	15	25.5	-1.7	1.087	0.5	0.5	0	37	21.5	0	121	84	0	35	34	34	
2025	11	14	8	52	15	25	-0.9	1.087	0.3	0.2	0	37.4	21.9	0	121	84	0	34	33	34	
2025	11	14	9	2	15	25.6	-2.4	1.087	0.3	0.2	0	36.5	21.1	0	120	83	0	35	34	34	
2025	11	14	9	12	15	26.8	-2.3	1.087	0.3	0.2	0	36.1	21.5	0	119	83	0	35	33	34	
2025	11	14	9	22	15	25.9	-1.8	1.088	0.5	0.4	0	37	20.6	0	120	82	0	34	34	34	
2025	11	14	9	32	15	25.8	-2.5	1.087	0.5	0.4	0	36.5	21.1	0	119	82	0	34	33	34	
2025	11	14	9	42	15	24.6	-1.3	1.087	0.4	0.3	0	36.5	21.1	0	120	83	0	35	34	34	
2025	11	14	9	52	15	24.6	-2.1	1.086	0.5	0.4	0	36.5	21.1	0	120	83	0	35	34	35	
2025	11	14	10	2	15	24.8	-1.7	1.087	0.5	0.4	0	36.5	21.5	0	119	83	0	34	33	35	
2025	11	14	10	12	15	25.8	-2	1.086	0.4	0.3	0	36.1	21.1	0	119	82	0	35	33	34	
2025	11	14	10	22	15	26	-2	1.088	0.4	0.3	0	36.5	21.1	0	120	83	0	35	34	34	
2025	11	14	10	32	15	24.6	-1.3	1.086	0.5	0.4	0	37	21.1	0	120	83	0	34	34	34	
2025	11	14	10	42	15	25.9	-1.3	1.086	0.3	0.2	0	36.1	21.5	0	119	83	0	35	33	34	
2025	11	14	10	52	15	24.9	-1.7	1.087	0.3	0.2	0	36.1	21.1	0	119	82	0	35	33	35	
2025	11	14	11	2	15	25	-0.4	1.086	0.3	0.2	0	36.1	21.5	0	119	83	0	35	33	35	
2025	11	14	11	12	15	25.5	-2.1	1.087	0.3	0.2	0	36.1	20.6	0	119	82	0	35	34	34	
2025	11	14	11	22	15	24.6	-2.3	1.087	0.4	0.3	0	37	21.5	0	120	83	0	34	33	35	
2025	11	14	11	32	15	25	-1.7	1.087	0.4	0.3	0	37	21.1	0	120	83	0	34	34	34	
2025	11	14	11	42	15	26.2	-0.8	1.086	0.4	0.3	0	36.5	21.5	0	120	84	0	35	34	34	
2025	11	14	11	52	15	25.6	-1.1	1.087	0.4	0.3	0	37.4	21.9	0	121	85	0	34	34	34	
2025	11	14	12	2	15	25.3	-2.4	1.087	0.4	0.3	0	36.5	21.5	0	119	84	0	34	34	34	
2025	11	14	12	12	15	24.6	-0.7	1.088	0.5	0.4	0	36.5	21.1	0	120	83	0	35	34	35	
2025	11	14	12	22	15	25.1	-1.7	1.086	0.5	0.5	0	36.1	21.5	0	119	83	0	35	33	34	
2025	11	14	12	32	15	25.5	-1.4	1.087	0.3	0.2	0	36.1	21.1	0	119	82	0	35	33	34	
2025	11	14	12	42	15	25.1	-2.2	1.087	0.3	0.2	0	35.7	21.1	0	118	82	0	35	33	34	
2025	11	14	12	52	15	24.6	-1.1	1.087	0.3	0.2	0	37	21.9	0	120	84	0	34	33	34	
2025	11	14	13	2	15	25.1	-0.6	1.086	0.3	0.2	0	37	22.4	0	121	85	0	35	33	34	
2025	11	14	13	12	15	24.4	-1.8	1.088	0.4	0.3	0	36.1	21.5	0	119	83	0	35	33	34	
2025	11	14	13	22	15	25.1	-1.2	1.087	0.4	0.3	0	36.5	21.1	0	119	83	0	34	34	34	
2025	11	14	13	32	15	25.2	-1.5	1.087	0.4	0.3	0	36.1	20.6	0	119	82	0	35	34	34	
2025	11	14	13	42	15	24.8	-0.4	1.087	0.4	0.3	0	36.5	21.5	0	119	83	0	34	33	34	
2025	11	14	13	52	15	25.6	-1.6	1.088	0.4	0.3	0	36.5	21.1	0	119	83	0	34	34	34	
2025	11	14	14	2	15	24.7	-1.4	1.087	0.5	0.4	0	36.1	21.5	0	119	83	0	35	33	34	
2025	11	14	14	12	15	25.6	-1.9	1.087	0.4	0.3	0	37	21.5	0	120	83	0	34	33	35	
2025	11	14	14	22	15	25.5	-2.2	1.087	0.5	0.4	0	36.5	21.5	0	119	83	0	34	33	34	
2025	11	14	14	32	15	26.5	-2	1.087	0.4	0.3	0	36.1	21.1	0	119	83	0	35	34	34	
2025	11	14	14	42	15	25.1	-2.6	1.086	0.5	0.4	0	36.5	21.1	0	119	82	0	34	33	34	
2025	11	14	14	52	15	26.4	-2.1	1.087	0.4	0.3	0	35.7	20.6	0	118	82	0	35	34	34	
2025	11	14	15	2	15	26.1	-1.9	1.087	0.3	0.2	0	35.7	21.1	0	118	82	0	35	33	34	
2025	11	14	15	12	15	24.7	-2.1	1.086	0.4	0.3	0	35.7	21.1	0	118	82	0	35	33	35	
2025	11	14	15	22	15	25.5	-1.3	1.087	0.4	0.3	0	36.1	21.1	0	118	82	0	34	33	35	
2025	11	14	15	32	15	26	-2.5	1.087	0.5	0.5	0	35.7	20.2	0	118	81	0	35	34	35	
2025	11	14	15	42	15	25.7	-1.3	1.087	0.4	0.3	0	36.1	21.5	0	119	83	0	35	33	34	
2025	11	14	15	52	15	26.8	-2.2	1.087	0.4	0.3	0	36.1	20.6	0	119	82	0	35	34	34	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	14	16	2	15	26.7	-3.7	1.088	0.3	0.2	0	36.5	21.1	0	119	82	0	34	33	34
2025	11	14	16	12	15	26.5	-2.1	1.088	0.3	0.2	0	36.1	20.6	0	119	82	0	35	34	34
2025	11	14	16	22	15	26	-2.8	1.088	0.3	0.2	0	36.1	21.1	0	119	82	0	35	33	34
2025	11	14	16	32	15	25	-2.4	1.088	0.4	0.3	0	36.5	20.6	0	119	82	0	34	34	34
2025	11	14	16	42	15	25.1	-1.6	1.087	0.3	0.2	0	36.5	21.1	0	119	82	0	34	33	34
2025	11	14	16	52	15	26.3	-1.9	1.088	0.4	0.3	0	36.5	21.5	0	120	83	0	35	33	34
2025	11	14	17	2	15	27.5	-2.3	1.088	0.3	0.2	0	36.5	20.6	0	119	82	0	34	34	34
2025	11	14	17	12	15	25.8	-1.6	1.088	0.4	0.3	0	36.5	21.5	0	120	83	0	35	33	34
2025	11	14	17	22	15	26.6	-3.2	1.088	0.4	0.3	0	37	21.5	0	120	83	0	34	33	34
2025	11	14	17	32	15	26.4	-1.6	1.088	0.3	0.2	0	37	21.5	0	121	83	0	35	33	34
2025	11	14	17	42	15	26.6	-2.7	1.087	0.3	0.2	0	36.5	20.6	0	120	82	0	35	34	34
2025	11	14	17	52	15	27.3	-2.8	1.087	0.3	0.2	0	37	21.5	0	121	83	0	35	33	34
2025	11	14	18	2	15	27	-2.6	1.087	0.3	0.2	0	37	21.5	0	121	83	0	35	33	34
2025	11	14	18	12	15	26.9	-3.3	1.087	0.3	0.2	0	37	21.1	0	121	83	0	35	34	34
2025	11	14	18	22	15	26.7	-3.2	1.087	0.3	0.2	0	37.4	21.5	0	122	84	0	35	34	34
2025	11	14	18	32	15	26	-3.4	1.087	0.3	0.2	0	37.4	21.9	0	122	84	0	35	33	33
2025	11	14	18	42	15	26.9	-2.5	1.087	0.4	0.3	0	37.8	22.4	0	122	85	0	34	33	34
2025	11	14	18	52	15	26.7	-2.9	1.087	0.4	0.3	0	38.3	22.4	0	123	85	0	34	33	34
2025	11	14	19	2	15	25.9	-2.3	1.087	0.5	0.4	0	37.8	22.4	0	123	86	0	35	34	34
2025	11	14	19	12	15	26.8	-2.5	1.087	0.5	0.4	0	38.3	22.4	0	123	85	0	34	33	34
2025	11	14	19	22	15	27.3	-3.1	1.087	0.5	0.4	0	38.7	22.8	0	124	87	0	34	34	34
2025	11	14	19	32	15	25.9	-2.4	1.087	0.4	0.3	0	38.3	22.8	0	123	86	0	34	33	34
2025	11	14	19	42	15	26.4	-2	1.087	0.3	0.2	0	37.8	21.9	0	123	85	0	35	34	34
2025	11	14	19	52	15	25.7	-3	1.087	0.4	0.3	0	37.8	22.8	0	123	86	0	35	33	35
2025	11	14	20	2	15	27	-2.6	1.087	0.4	0.3	0	37.8	22.8	0	123	86	0	35	33	35
2025	11	14	20	12	15	27.3	-2.6	1.087	0.4	0.3	0	38.3	22.4	0	123	86	0	34	34	35
2025	11	14	20	22	15	27.6	-3.6	1.087	0.3	0.2	0	37.8	22.8	0	123	86	0	35	33	34
2025	11	14	20	32	15	25.8	-2.5	1.086	0.5	0.4	0	37.8	21.9	0	123	85	0	35	34	34
2025	11	14	20	42	15	26.5	-3.3	1.086	0.5	0.4	0	38.3	22.8	0	123	86	0	34	33	34
2025	11	14	20	52	15	26.3	-3.2	1.086	0.4	0.3	0	38.3	22.8	0	123	86	0	34	33	34
2025	11	14	21	2	15	25.7	-2.5	1.086	0.4	0.3	0	37.8	22.4	0	123	85	0	35	33	34
2025	11	14	21	12	15	26.3	-2.5	1.086	0.5	0.4	0	38.3	21.9	0	123	85	0	34	34	34
2025	11	14	21	22	15	26.6	-2.9	1.086	0.5	0.4	0	38.3	22.8	0	124	86	0	35	33	34
2025	11	14	21	32	15	26.8	-3.3	1.086	0.4	0.3	0	38.7	22.8	0	124	86	0	34	33	35
2025	11	14	21	42	15	27.1	-2.7	1.086	0.3	0.2	0	38.3	22.8	0	124	86	0	35	33	34
2025	11	14	21	52	15	26.7	-2.9	1.086	0.5	0.4	0	38.7	22.4	0	124	86	0	34	34	35
2025	11	14	22	2	15	25.9	-3	1.086	0.5	0.4	0	38.3	22.8	0	124	86	0	35	33	34
2025	11	14	22	12	15	27.3	-3.3	1.085	0.4	0.3	0	38.7	22.8	0	124	86	0	34	33	34
2025	11	14	22	22	15	26.2	-2.5	1.085	0.4	0.3	0	38.7	22.8	0	125	87	0	35	34	34
2025	11	14	22	32	15	26.2	-2.8	1.085	0.4	0.3	0	38.7	22.4	0	124	86	0	34	34	34
2025	11	14	22	42	15	25.6	-4.2	1.085	0.3	0.2	0	38.3	23.2	0	124	87	0	35	33	34
2025	11	14	22	52	15	26	-2.3	1.085	0.3	0.2	0	38.3	22.8	0	124	87	0	35	34	34
2025	11	14	23	2	15	25.9	-3	1.085	0.5	0.4	0	38.7	23.2	0	125	87	0	35	33	34
2025	11	14	23	12	15	26.2	-3.4	1.085	0.4	0.3	0	39.1	23.2	0	125	87	0	34	33	35
2025	11	14	23	22	15	25.5	-3.1	1.084	0.4	0.3	0	39.1	23.2	0	125	87	0	34	33	34
2025	11	14	23	32	15	26.2	-2	1.084	0.4	0.3	0	39.1	23.2	0	126	88	0	35	34	34
2025	11	14	23	42	15	27.8	-2.8	1.084	0.4	0.3	0	39.6	23.6	0	126	89	0	34	34	34
2025	11	14	23	52	15	25.6	-2.5	1.083	0.4	0.3	0	39.6	23.6	0	126	88	0	34	33	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	15	0	2	15	25.9	-2.5	1.082	0.4	0.3	0	39.6	23.6	0	126	88	0	34	33	35
2025	11	15	0	12	15	26.6	-2.1	1.082	0.5	0.4	0	38.7	23.2	0	125	87	0	35	33	34
2025	11	15	0	22	15	26.4	-2.4	1.081	0.5	0.4	0	38.7	23.2	0	125	87	0	35	33	34
2025	11	15	0	32	15	26.5	-1.7	1.081	0.4	0.3	0	38.7	23.6	0	125	88	0	35	33	35
2025	11	15	0	42	15	26.7	-2.3	1.081	0.3	0.2	0	39.1	23.6	0	125	88	0	34	33	34
2025	11	15	0	52	15	26.4	-2.7	1.08	0.3	0.2	0	40	24.5	0	128	91	0	35	34	35
2025	11	15	1	2	15	25.5	-1.9	1.08	0.3	0.2	0	39.6	24.1	0	127	89	0	35	33	34
2025	11	15	1	12	15	25.2	-3.1	1.08	0.5	0.4	0	40.4	24.1	0	128	90	0	34	34	34
2025	11	15	1	22	15	25.4	-3.1	1.08	0.3	0.2	0	41.3	25.8	0	130	93	0	34	33	34
2025	11	15	1	32	15	25.9	-2.1	1.08	0.4	0.3	0	40.4	25.4	0	129	92	0	35	33	34
2025	11	15	1	42	15	26.6	-2.7	1.08	0.4	0.3	0	40.4	24.9	0	130	92	0	36	34	35
2025	11	15	1	52	15	25.9	-2.7	1.08	0.3	0.2	0	41.3	25.4	0	131	93	0	35	34	33
2025	11	15	2	2	15	26.4	-2.1	1.08	0.5	0.4	0	40.9	25.4	0	130	93	0	35	34	35
2025	11	15	2	12	15	25.8	-1.3	1.08	0.4	0.3	0	40.9	25.4	0	130	92	0	35	33	35
2025	11	15	2	22	15	26.4	-2.6	1.08	0.4	0.3	0	42.1	26.2	0	132	95	0	34	34	35
2025	11	15	2	32	15	26.2	-3.1	1.08	0.3	0.2	0	42.1	26.2	0	132	95	0	34	34	34
2025	11	15	2	42	15	26.7	-2.9	1.08	0.3	0.2	0	41.3	25.4	0	131	93	0	35	34	35
2025	11	15	2	52	15	26.8	-3.3	1.08	0.4	0.3	0	40.9	25.4	0	129	92	0	34	33	34
2025	11	15	3	2	15	25.3	-2.4	1.08	0.4	0.3	0	42.1	25.8	0	132	94	0	34	34	34
2025	11	15	3	12	15	25.8	-2.5	1.08	0.5	0.5	0	41.3	26.2	0	131	94	0	35	33	34
2025	11	15	3	22	15	25.9	-2.6	1.08	0.5	0.4	0	41.3	25.4	0	130	92	0	34	33	34
2025	11	15	3	32	15	24.8	-2.1	1.08	0.4	0.3	0	40	24.9	0	128	91	0	35	33	34
2025	11	15	3	42	15	24.7	-2.6	1.08	0.3	0.2	0	40	24.5	0	128	91	0	35	34	35
2025	11	15	3	52	15	25.5	-2.9	1.08	0.5	0.4	0	40.4	24.9	0	128	91	0	34	33	33
2025	11	15	4	2	15	26.2	-3.8	1.08	0.4	0.3	0	39.6	24.5	0	127	90	0	35	33	34
2025	11	15	4	12	15	24	-1.9	1.08	0.3	0.2	0	39.6	24.5	0	127	90	0	35	33	34
2025	11	15	4	22	15	26.1	-2.5	1.079	0.4	0.3	0	39.6	23.6	0	126	89	0	34	34	34
2025	11	15	4	32	15	25.9	-3.3	1.079	0.5	0.4	0	39.1	24.1	0	126	90	0	35	34	34
2025	11	15	4	42	15	26.3	-2.4	1.079	0.4	0.3	0	39.1	24.1	0	126	89	0	35	33	35
2025	11	15	4	52	15	25.9	-2.3	1.079	0.3	0.2	0	39.1	23.6	0	126	89	0	35	34	34
2025	11	15	5	2	15	27.2	-2.9	1.079	0.3	0.2	0	39.6	23.6	0	126	89	0	34	34	33
2025	11	15	5	12	15	25.4	-1.8	1.079	0.5	0.4	0	39.1	24.1	0	125	89	0	34	33	34
2025	11	15	5	22	15	25.5	-2.7	1.078	0.5	0.4	0	39.6	24.1	0	126	90	0	34	34	35
2025	11	15	5	32	15	25.9	-2.1	1.078	0.5	0.5	0	39.6	24.1	0	126	89	0	34	33	34
2025	11	15	5	42	15	26	-3.1	1.078	0.3	0.2	0	38.7	24.1	0	125	89	0	35	33	34
2025	11	15	5	52	15	25.2	-2.6	1.078	0.5	0.4	0	39.6	24.1	0	126	89	0	34	33	34
2025	11	15	6	2	15	25.4	-2.3	1.078	0.5	0.4	0	38.7	24.1	0	125	89	0	35	33	35
2025	11	15	6	12	15	25.6	-2.1	1.078	0.3	0.2	0	39.1	24.1	0	125	89	0	34	33	34
2025	11	15	6	22	15	25.7	-3.4	1.078	0.4	0.3	0	38.7	23.2	0	125	88	0	35	34	34
2025	11	15	6	32	15	25.7	-1.8	1.078	0.3	0.2	0	39.1	23.6	0	125	88	0	34	33	34
2025	11	15	6	42	15	25.5	-3.1	1.078	0.4	0.3	0	39.1	23.6	0	125	88	0	34	33	34
2025	11	15	6	52	15	26.4	-3.3	1.078	0.3	0.2	0	38.7	23.6	0	125	88	0	35	33	34
2025	11	15	7	2	15	25.5	-2.6	1.078	0.3	0.2	0	39.1	23.2	0	125	88	0	34	34	33
2025	11	15	7	12	15	23.8	-1.8	1.077	0.5	0.4	0	38.7	23.2	0	125	87	0	35	33	34
2025	11	15	7	22	15	26.8	-2.5	1.077	0.5	0.4	0	38.3	23.6	0	124	88	0	35	33	34
2025	11	15	7	32	15	26.1	-3	1.077	0.5	0.4	0	39.1	23.2	0	125	88	0	34	34	34
2025	11	15	7	42	15	26	-2.1	1.077	0.4	0.3	0	38.7	23.6	0	124	88	0	34	33	35
2025	11	15	7	52	15	25.8	-2.5	1.077	0.4	0.3	0	38.7	24.1	0	125	89	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	15	8	2	15	26.1	-1.7	1.077	0.4	0.3	0	37.8	22.4	0	123	86	0	35	34	34
2025	11	15	8	12	15	25.7	-3	1.077	0.5	0.4	0	37.8	23.2	0	123	86	0	35	32	34
2025	11	15	8	22	15	26	-3.1	1.077	0.4	0.3	0	37.8	22.8	0	123	86	0	35	33	35
2025	11	15	8	32	15	25.7	-3.1	1.077	0.5	0.4	0	37.8	22.8	0	123	86	0	35	33	34
2025	11	15	8	42	15	27.1	-2.7	1.077	0.4	0.3	0	37.4	22.4	0	122	85	0	35	33	34
2025	11	15	8	52	15	26.4	-2.8	1.077	0.3	0.2	0	37.4	21.9	0	121	84	0	34	33	34
2025	11	15	9	2	15	26.9	-2.5	1.077	0.3	0.2	0	37.4	21.9	0	121	84	0	34	33	34
2025	11	15	9	12	15	26.1	-2.7	1.076	0.3	0.2	0	37	21.9	0	120	84	0	34	33	34
2025	11	15	9	22	15	26.6	-3.5	1.076	0.5	0.4	0	37	21.5	0	120	84	0	34	34	35
2025	11	15	9	32	15	25.8	-2.9	1.076	0.4	0.3	0	37	21.9	0	120	84	0	34	33	34
2025	11	15	9	42	15	25.4	-2.2	1.076	0.4	0.3	0	37	21.9	0	121	84	0	35	33	34
2025	11	15	9	52	15	25.1	-2.6	1.075	0.5	0.4	0	37	21.9	0	120	84	0	34	33	34
2025	11	15	10	2	15	25.5	-2.5	1.075	0.3	0.2	0	37	21.5	0	120	84	0	34	34	34
2025	11	15	10	12	15	26	-2.3	1.075	0.3	0.2	0	37	21.9	0	120	84	0	34	33	34
2025	11	15	10	22	15	26.7	-2.3	1.075	0.3	0.2	0	36.1	21.5	0	119	83	0	35	33	34
2025	11	15	10	32	15	25.9	-2.8	1.075	0.3	0.2	0	37	21.1	0	120	83	0	34	34	34
2025	11	15	10	42	15	26	-2.8	1.075	0.4	0.3	0	36.5	21.1	0	119	83	0	34	34	33
2025	11	15	10	52	15	24.8	-1.4	1.075	0.4	0.3	0	37	21.5	0	120	83	0	34	33	34
2025	11	15	11	2	15	25.6	-2	1.074	0.4	0.3	0	36.1	21.5	0	119	83	0	35	33	34
2025	11	15	11	12	15	26	-3.8	1.074	0.4	0.3	0	36.5	21.5	0	120	83	0	35	33	35
2025	11	15	11	22	15	24.3	-2.2	1.074	0.5	0.4	0	36.5	21.1	0	119	83	0	34	34	34
2025	11	15	11	32	15	26.1	-3.2	1.073	0.3	0.2	0	36.5	21.1	0	119	83	0	34	34	35
2025	11	15	11	42	15	24.6	-3	1.072	0.4	0.3	0	36.5	21.5	0	120	83	0	35	33	34
2025	11	15	11	52	15	24.7	-2.9	1.072	0.3	0.2	0	36.1	21.1	0	119	83	0	35	34	34
2025	11	15	12	2	15	26.3	-2.5	1.071	0.3	0.2	0	37	21.1	0	120	83	0	34	34	34
2025	11	15	12	12	15	25.4	-2.6	1.071	0.3	0.2	0	37	21.5	0	120	84	0	34	34	34
2025	11	15	12	22	15	25	-3.2	1.071	0.4	0.3	0	36.5	21.1	0	119	82	0	34	33	34
2025	11	15	12	32	15	24.8	-2.8	1.07	0.4	0.3	0	36.5	21.5	0	120	83	0	35	33	34
2025	11	15	12	42	15	26.2	-1.8	1.07	0.4	0.3	0	36.1	21.1	0	119	82	0	35	33	34
2025	11	15	12	52	15	23.8	-1	1.07	0.4	0.3	0	36.5	21.5	0	119	83	0	34	33	34
2025	11	15	13	2	15	26.4	-1.8	1.07	0.5	0.4	0	37	21.5	0	120	83	0	34	33	34
2025	11	15	13	12	15	24.6	-1.2	1.07	0.3	0.2	0	36.5	21.5	0	119	83	0	34	33	35
2025	11	15	13	22	15	25.1	-2.3	1.07	0.4	0.3	0	37	21.5	0	120	83	0	34	33	34
2025	11	15	13	32	15	24.9	-3.1	1.07	0.3	0.2	0	37.8	22.4	0	122	85	0	34	33	34
2025	11	15	13	42	15	25.2	-2.4	1.07	0.4	0.3	0	37.8	22.8	0	122	86	0	34	33	34
2025	11	15	13	52	15	25.4	-3.8	1.071	0.4	0.3	0	37.4	22.8	0	122	86	0	35	33	33
2025	11	15	14	2	15	23.8	-1.8	1.072	0.4	0.3	0	37.8	22.8	0	122	86	0	34	33	34
2025	11	15	14	12	15	24.6	-2.3	1.073	0.5	0.4	0	37.8	22.8	0	122	86	0	34	33	34
2025	11	15	14	22	15	24.3	-2.6	1.073	0.5	0.4	0	39.1	23.6	0	125	89	0	34	34	34
2025	11	15	14	32	15	24.5	-2.2	1.075	0.3	0.2	0	38.7	23.6	0	125	89	0	35	34	34
2025	11	15	14	42	15	25.2	-1.2	1.076	0.4	0.3	0	38.7	24.1	0	125	89	0	35	33	35
2025	11	15	14	52	15	25.3	-1.7	1.076	0.4	0.3	0	39.1	24.1	0	126	89	0	35	33	34
2025	11	15	15	2	15	25.7	-2.5	1.076	0.3	0.2	0	38.7	24.1	0	125	89	0	35	33	34
2025	11	15	15	12	15	26.5	-2.5	1.077	0.3	0.2	0	39.1	23.6	0	125	88	0	34	33	34
2025	11	15	15	22	15	25.3	-2.2	1.077	0.3	0.2	0	39.1	24.1	0	126	89	0	35	33	34
2025	11	15	15	32	15	25.7	-2.1	1.077	0.4	0.3	0	38.7	23.6	0	125	89	0	35	34	34
2025	11	15	15	42	15	25.1	-2	1.078	0.4	0.3	0	39.6	24.5	0	127	91	0	35	34	34
2025	11	15	15	52	15	25.3	-2.9	1.078	0.3	0.2	0	39.1	24.1	0	126	89	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	15	16	2	15	24.5	-2.7	1.079	0.4	0.3	0	39.6	24.5	0	126	90	0	34	33	35
2025	11	15	16	12	15	26.3	-2.2	1.079	0.3	0.2	0	40	24.9	0	127	91	0	34	33	34
2025	11	15	16	22	15	25.7	-1.2	1.08	0.4	0.3	0	40.4	25.8	0	128	92	0	34	32	34
2025	11	15	16	32	15	25.1	-1.3	1.08	0.4	0.3	0	40	24.5	0	127	91	0	34	34	35
2025	11	15	16	42	15	25.6	-2.5	1.081	0.4	0.3	0	39.6	24.9	0	127	91	0	35	33	34
2025	11	15	16	52	15	26.2	-1.7	1.081	0.3	0.2	0	40.4	25.4	0	128	92	0	34	33	35
2025	11	15	17	2	15	27.2	-2.3	1.082	0.3	0.2	0	40	25.4	0	128	92	0	35	33	34
2025	11	15	17	12	15	25.2	-2.2	1.084	0.4	0.3	0	40	25.4	0	128	92	0	35	33	34
2025	11	15	17	22	15	26	-3.8	1.086	0.3	0.2	0	40	24.9	0	128	91	0	35	33	34
2025	11	15	17	32	15	26.6	-3.5	1.087	0.4	0.3	0	40.4	24.9	0	128	91	0	34	33	34
2025	11	15	17	42	15	25.9	-2.5	1.087	0.3	0.2	0	39.6	24.5	0	127	91	0	35	34	34
2025	11	15	17	52	15	24.7	-2.4	1.088	0.3	0.2	0	40.4	25.4	0	129	93	0	35	34	35
2025	11	15	18	2	15	26.6	-2.9	1.088	0.3	0.2	0	40.9	24.9	0	129	92	0	34	34	34
2025	11	15	18	12	15	26.5	-2.2	1.089	0.3	0.2	0	40	24.9	0	128	92	0	35	34	34
2025	11	15	18	22	15	26.5	-2.8	1.089	0.3	0.2	0	40.4	25.4	0	128	92	0	34	33	34
2025	11	15	18	32	15	26.5	-2.4	1.09	0.4	0.3	0	40.4	24.9	0	129	92	0	35	34	35
2025	11	15	18	42	15	24.7	-2.1	1.09	0.4	0.3	0	40.4	24.5	0	128	90	0	34	33	34
2025	11	15	18	52	15	26	-1.8	1.091	0.4	0.3	0	40.4	24.9	0	128	92	0	34	34	34
2025	11	15	19	2	15	27.1	-3	1.091	0.3	0.2	0	40.9	25.4	0	129	92	0	34	33	35
2025	11	15	19	12	15	26.5	-2.5	1.092	0.5	0.4	0	40	24.9	0	128	91	0	35	33	34
2025	11	15	19	22	15	25.9	-2.3	1.092	0.3	0.2	0	39.6	24.5	0	127	90	0	35	33	34
2025	11	15	19	32	15	26	-2	1.093	0.4	0.3	0	40	24.1	0	127	90	0	34	34	35
2025	11	15	19	42	15	24.7	-1.7	1.094	0.3	0.2	0	39.6	24.1	0	126	89	0	34	33	34
2025	11	15	19	52	15	27	-2	1.096	0.3	0.2	0	39.6	24.5	0	127	91	0	35	34	34
2025	11	15	20	2	15	27.1	-2.1	1.097	0.3	0.2	0	40.4	24.9	0	128	91	0	34	33	34
2025	11	15	20	12	15	26.2	-1.5	1.098	0.3	0.2	0	40	24.9	0	128	91	0	35	33	35
2025	11	15	20	22	15	26	-2.1	1.099	0.4	0.3	0	40	24.5	0	128	91	0	35	34	34
2025	11	15	20	32	15	26.1	-2.5	1.1	0.3	0.2	0	39.6	24.5	0	127	90	0	35	33	34
2025	11	15	20	42	15	26.3	-3.2	1.1	0.4	0.3	0	39.1	24.5	0	126	90	0	35	33	35
2025	11	15	20	52	15	25.9	-3.4	1.1	0.3	0.2	0	39.6	24.1	0	126	89	0	34	33	34
2025	11	15	21	2	15	26.1	-2.4	1.101	0.4	0.3	0	38.7	24.1	0	125	89	0	35	33	34
2025	11	15	21	12	15	26.4	-2.5	1.101	0.4	0.3	0	38.7	24.1	0	125	89	0	35	33	34
2025	11	15	21	22	15	25.7	-2.5	1.101	0.3	0.2	0	38.7	24.1	0	125	89	0	35	33	35
2025	11	15	21	32	15	26.2	-2.1	1.101	0.3	0.2	0	39.1	24.5	0	126	90	0	35	33	34
2025	11	15	21	42	15	26.8	-2.7	1.101	0.3	0.2	0	39.6	24.5	0	126	90	0	34	33	34
2025	11	15	21	52	15	27.7	-3.3	1.101	0.3	0.2	0	40.4	25.8	0	129	93	0	35	33	34
2025	11	15	22	2	15	26.8	-3.4	1.102	0.5	0.4	0	41.3	26.2	0	130	94	0	34	33	34
2025	11	15	22	12	15	26.2	-2.8	1.102	0.4	0.3	0	39.6	23.6	0	126	89	0	34	34	34
2025	11	15	22	22	15	26.7	-2	1.103	0.3	0.2	0	39.1	24.5	0	126	90	0	35	33	34
2025	11	15	22	32	15	26.4	-3.2	1.103	0.4	0.3	0	39.1	24.9	0	126	90	0	35	32	34
2025	11	15	22	42	15	26.8	-3.4	1.103	0.5	0.4	0	38.7	23.6	0	125	89	0	35	34	34
2025	11	15	22	52	15	27	-1.2	1.103	0.3	0.2	0	38.7	23.6	0	125	88	0	35	33	35
2025	11	15	23	2	15	27.9	-2.2	1.104	0.5	0.4	0	39.1	23.6	0	125	88	0	34	33	34
2025	11	15	23	12	15	27.6	-2.1	1.104	0.3	0.2	0	38.7	24.5	0	125	90	0	35	33	34
2025	11	15	23	22	15	26.8	-3.4	1.104	0.5	0.4	0	39.1	24.1	0	125	89	0	34	33	34
2025	11	15	23	32	15	26.1	-2.7	1.104	0.3	0.2	0	39.1	23.6	0	125	89	0	34	34	35
2025	11	15	23	42	15	25.4	-2.8	1.104	0.3	0.2	0	39.6	24.5	0	126	91	0	34	34	34
2025	11	15	23	52	15	26.2	-1.8	1.104	0.4	0.3	0	40	26.2	0	127	94	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	16	0	2	15	26.9	-3.4	1.106	0.3	0.2	0	39.6	25.4	0	126	92	0	34	33	34
2025	11	16	0	12	15	27.2	-3.7	1.107	0.4	0.3	0	40.4	25.8	0	128	93	0	34	33	34
2025	11	16	0	22	15	25.8	-2.4	1.108	0.3	0.2	0	40.4	25.8	0	128	94	0	34	34	33
2025	11	16	0	32	15	26.6	-2.9	1.109	0.3	0.2	0	40	25.8	0	128	94	0	35	34	34
2025	11	16	0	42	15	26	-2.5	1.109	0.3	0.2	0	40	25.4	0	127	93	0	34	34	34
2025	11	16	0	52	15	25.9	-3.1	1.11	0.3	0.2	0	39.6	25.4	0	127	92	0	35	33	34
2025	11	16	1	2	15	26.6	-1.7	1.109	0.3	0.2	0	39.1	25.4	0	126	92	0	35	33	34
2025	11	16	1	12	15	25.6	-1.5	1.109	0.3	0.2	0	40	24.9	0	127	92	0	34	34	35
2025	11	16	1	22	15	26.8	-2.5	1.109	0.3	0.2	0	39.6	24.9	0	126	92	0	34	34	34
2025	11	16	1	32	15	26.9	-2.3	1.109	0.4	0.3	0	39.6	24.9	0	126	91	0	34	33	34
2025	11	16	1	42	15	25.6	-1.7	1.109	0.3	0.2	0	39.1	24.9	0	125	91	0	34	33	34
2025	11	16	1	52	15	27.1	-2.9	1.109	0.3	0.2	0	38.7	24.9	0	124	91	0	34	33	34
2025	11	16	2	2	15	26.7	-2	1.109	0.3	0.2	0	39.1	24.9	0	125	91	0	34	33	34
2025	11	16	2	12	15	26.8	-2.6	1.11	0.3	0.2	0	39.1	24.9	0	125	91	0	34	33	34
2025	11	16	2	22	15	26.6	-2.5	1.11	0.4	0.3	0	38.3	24.5	0	124	91	0	35	34	34
2025	11	16	2	32	15	26	-2.3	1.109	0.5	0.4	0	38.3	24.5	0	124	91	0	35	34	34
2025	11	16	2	42	15	25.7	-1.5	1.109	0.3	0.2	0	38.3	24.5	0	124	90	0	35	33	34
2025	11	16	2	52	15	26	-2.1	1.108	0.3	0.2	0	38.3	24.9	0	124	91	0	35	33	34
2025	11	16	3	2	15	26.3	-2.7	1.109	0.4	0.3	0	38.7	24.5	0	124	91	0	34	34	35
2025	11	16	3	12	15	26.8	-2.9	1.108	0.3	0.2	0	37.8	24.5	0	123	90	0	35	33	35
2025	11	16	3	22	15	26	-2.6	1.108	0.3	0.2	0	38.3	24.5	0	124	90	0	35	33	34
2025	11	16	3	32	15	26.4	-1.9	1.108	0.3	0.2	0	38.7	24.9	0	124	91	0	34	33	34
2025	11	16	3	42	15	26.7	-2.9	1.108	0.5	0.4	0	38.3	24.5	0	124	90	0	35	33	34
2025	11	16	3	52	15	26	-3.1	1.109	0.5	0.4	0	38.3	24.9	0	124	91	0	35	33	34
2025	11	16	4	2	15	26.7	-2.3	1.108	0.4	0.3	0	38.7	24.5	0	124	90	0	34	33	34
2025	11	16	4	12	15	25.4	-2.5	1.108	0.3	0.2	0	38.3	24.9	0	124	91	0	35	33	34
2025	11	16	4	22	15	26.4	-2.6	1.108	0.3	0.2	0	38.3	24.1	0	123	90	0	34	34	35
2025	11	16	4	32	15	25.5	-2.4	1.106	0.4	0.3	0	37.8	24.1	0	123	89	0	35	33	34
2025	11	16	4	42	15	24.7	-2.7	1.107	0.5	0.4	0	38.7	24.5	0	124	90	0	34	33	34
2025	11	16	4	52	15	25.2	-2.6	1.106	0.4	0.3	0	38.3	24.1	0	124	90	0	35	34	34
2025	11	16	5	2	15	25.6	-2.1	1.107	0.4	0.3	0	38.3	24.1	0	123	89	0	34	33	34
2025	11	16	5	12	15	25.4	-1.3	1.107	0.3	0.2	0	37.8	22.4	0	123	86	0	35	34	34
2025	11	16	5	22	15	26	-1.7	1.106	0.3	0.2	0	37.8	23.6	0	123	88	0	35	33	34
2025	11	16	5	32	15	24.9	-2.3	1.107	0.3	0.2	0	37.8	24.1	0	123	89	0	35	33	34
2025	11	16	5	42	15	25.5	-2.4	1.106	0.3	0.2	0	38.3	24.1	0	123	89	0	34	33	34
2025	11	16	5	52	15	26.1	-2.5	1.106	0.3	0.2	0	37.8	23.6	0	123	88	0	35	33	34
2025	11	16	6	2	15	26.2	-2.6	1.106	0.3	0.2	0	38.3	23.6	0	123	88	0	34	33	34
2025	11	16	6	12	15	26.1	-1.6	1.106	0.4	0.3	0	37.8	23.6	0	123	88	0	35	33	35
2025	11	16	6	22	15	26.1	-3.3	1.106	0.3	0.2	0	37.8	23.2	0	122	87	0	34	33	34
2025	11	16	6	32	15	25.5	-2.5	1.105	0.3	0.2	0	37.4	23.2	0	122	88	0	35	34	34
2025	11	16	6	42	15	26.3	-2.1	1.106	0.4	0.3	0	37.8	23.2	0	122	87	0	34	33	34
2025	11	16	6	52	15	26.4	-1.9	1.105	0.4	0.3	0	37.8	22.8	0	122	87	0	34	34	34
2025	11	16	7	2	15	26.4	-1.5	1.105	0.4	0.3	0	37.4	22.8	0	122	87	0	35	34	34
2025	11	16	7	12	15	25.5	-2.7	1.105	0.4	0.3	0	37.4	22.8	0	121	87	0	34	34	34
2025	11	16	7	22	15	25.7	-2.6	1.104	0.3	0.2	0	37	22.4	0	121	86	0	35	34	34
2025	11	16	7	32	15	24.8	-1.9	1.103	0.5	0.4	0	37.4	22.4	0	121	86	0	34	34	34
2025	11	16	7	42	15	26.8	-3.9	1.105	0.5	0.4	0	36.5	22.4	0	120	86	0	35	34	34
2025	11	16	7	52	15	26.5	-2.9	1.104	0.3	0.2	0	37	22.8	0	120	86	0	34	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	16	8	2	15	25.6	-2.2	1.103	0.4	0.3	0	37.4	22.8	0	121	86	0	34	33	34
2025	11	16	8	12	15	25.7	-2.3	1.104	0.3	0.2	0	37.4	22.8	0	121	86	0	34	33	34
2025	11	16	8	22	15	26.2	-2.1	1.105	0.3	0.2	0	37	22.8	0	120	86	0	34	33	35
2025	11	16	8	32	15	25.1	-1.7	1.103	0.3	0.2	0	36.5	22.4	0	119	85	0	34	33	34
2025	11	16	8	42	15	26.8	-2.5	1.104	0.3	0.2	0	36.5	22.4	0	120	85	0	35	33	35
2025	11	16	8	52	15	26	-1.4	1.103	0.4	0.3	0	36.1	22.4	0	119	86	0	35	34	34
2025	11	16	9	2	15	25.1	-2.8	1.103	0.4	0.3	0	36.1	22.4	0	119	85	0	35	33	34
2025	11	16	9	12	15	25.4	-2.6	1.103	0.3	0.2	0	36.5	21.9	0	120	85	0	35	34	34
2025	11	16	9	22	15	24.7	-1.8	1.103	0.4	0.3	0	36.5	22.4	0	120	85	0	35	33	34
2025	11	16	9	32	15	26.4	-2.5	1.102	0.3	0.2	0	36.5	21.9	0	119	84	0	34	33	34
2025	11	16	9	42	15	25.3	-2.5	1.102	0.4	0.3	0	36.1	21.5	0	119	84	0	35	34	34
2025	11	16	9	52	15	26.9	-1.6	1.102	0.4	0.3	0	36.1	21.5	0	118	84	0	34	34	34
2025	11	16	10	2	15	24.1	-2.5	1.102	0.5	0.4	0	36.1	21.5	0	119	84	0	35	34	34
2025	11	16	10	12	15	25.7	-3.1	1.102	0.4	0.3	0	36.5	22.4	0	119	85	0	34	33	34
2025	11	16	10	22	15	26	-2.5	1.102	0.4	0.3	0	35.7	21.9	0	118	84	0	35	33	34
2025	11	16	10	32	15	25.4	-3.3	1.101	0.3	0.2	0	36.1	22.4	0	118	85	0	34	33	34
2025	11	16	10	42	15	26	-2.6	1.101	0.5	0.5	0	36.1	21.9	0	118	84	0	34	33	34
2025	11	16	10	52	15	25.6	-1.5	1.101	0.3	0.2	0	36.1	21.9	0	118	84	0	34	33	35
2025	11	16	11	2	15	25.6	-1.8	1.101	0.4	0.3	0	36.1	21.9	0	118	84	0	34	33	35
2025	11	16	11	12	15	25.8	-2.1	1.101	0.3	0.2	0	35.7	21.5	0	118	84	0	35	34	34
2025	11	16	11	22	15	25.1	-1.3	1.101	0.5	0.4	0	36.1	22.4	0	119	85	0	35	33	34
2025	11	16	11	32	15	25.5	-1.9	1.101	0.4	0.3	0	35.7	21.9	0	118	84	0	35	33	35
2025	11	16	11	42	15	25.6	-3.4	1.101	0.3	0.2	0	35.7	21.5	0	118	84	0	35	34	35
2025	11	16	11	52	15	26	-2.3	1.101	0.4	0.3	0	36.1	21.9	0	119	85	0	35	34	35
2025	11	16	12	2	15	25.4	-3	1.101	0.4	0.3	0	36.1	21.9	0	119	84	0	35	33	34
2025	11	16	12	12	15	24.7	-1.8	1.1	0.4	0.3	0	36.1	21.9	0	119	85	0	35	34	35
2025	11	16	12	22	15	25.6	-2.2	1.101	0.5	0.4	0	38.3	22.4	0	123	85	0	34	33	34
2025	11	16	12	32	15	24.3	-2.1	1.099	0.4	0.3	0	38.3	22.8	0	124	86	0	35	33	34
2025	11	16	12	42	15	25.5	-1.7	1.101	0.4	0.3	0	38.3	22.4	0	124	85	0	35	33	35
2025	11	16	12	52	15	25.9	-1.7	1.1	0.4	0.3	0	38.3	21.9	0	123	85	0	34	34	34
2025	11	16	13	2	15	25.1	-2.1	1.1	0.5	0.4	0	38.3	22.4	0	123	85	0	34	33	34
2025	11	16	13	12	15	25.1	-3	1.101	0.4	0.3	0	37.8	21.5	0	122	84	0	34	34	34
2025	11	16	13	22	15	25.2	-1.3	1.099	0.4	0.3	0	37.8	22.4	0	123	85	0	35	33	35
2025	11	16	13	32	15	25.8	-1.9	1.1	0.4	0.3	0	37.8	22.8	0	123	86	0	35	33	34
2025	11	16	13	42	15	25.1	-2.7	1.101	0.5	0.4	0	37.8	22.8	0	123	86	0	35	33	35
2025	11	16	13	52	15	24.9	-1.5	1.099	0.3	0.2	0	37.4	22.4	0	122	85	0	35	33	34
2025	11	16	14	2	15	26.6	-2.1	1.1	0.4	0.3	0	37.8	22.4	0	123	86	0	35	34	35
2025	11	16	14	12	15	25.1	-1.8	1.1	0.4	0.3	0	38.7	22.8	0	124	87	0	34	34	35
2025	11	16	14	22	15	24	-1.1	1.1	0.4	0.3	0	38.3	22.8	0	124	87	0	35	34	34
2025	11	16	14	32	15	24.2	-1.4	1.098	0.5	0.4	0	38.3	23.6	0	124	88	0	35	33	34
2025	11	16	14	42	15	25.1	-1	1.1	0.3	0.2	0	38.3	22.8	0	124	86	0	35	33	34
2025	11	16	14	52	15	24.7	-1.7	1.099	0.4	0.3	0	38.7	23.2	0	124	87	0	34	33	34
2025	11	16	15	2	15	24.8	-1.9	1.099	0.4	0.3	0	39.1	24.5	0	125	90	0	34	33	34
2025	11	16	15	12	15	24.7	-1.8	1.101	0.3	0.2	0	39.1	23.2	0	125	87	0	34	33	34
2025	11	16	15	22	15	25.1	-2.1	1.1	0.3	0.2	0	39.1	23.2	0	125	88	0	34	34	34
2025	11	16	15	32	15	24.7	-2.1	1.1	0.3	0.2	0	37.8	22.8	0	123	86	0	35	33	34
2025	11	16	15	42	15	24.9	-1.8	1.1	0.3	0.2	0	37.8	23.2	0	123	87	0	35	33	34
2025	11	16	15	52	15	24.6	-2.2	1.099	0.5	0.5	0	37.8	21.5	0	123	84	0	35	34	34

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	11	16	16	2	15	25.3	-1.4	1.1	0.3	0.2	0	38.3	22.4	0	124	86	0	35	34	34	
2025	11	16	16	12	15	26.6	-1.4	1.099	0.3	0.2	0	37.4	21.9	0	122	84	0	35	33	34	
2025	11	16	16	22	15	25.9	-3	1.1	0.3	0.2	0	37.4	21.9	0	122	84	0	35	33	34	
2025	11	16	16	32	15	25.2	-2.3	1.1	0.3	0.2	0	37.8	21.5	0	123	83	0	35	33	34	
2025	11	16	16	42	15	25.6	-2.9	1.1	0.3	0.2	0	37.4	21.1	0	122	82	0	35	33	35	
2025	11	16	16	52	15	25	-2.2	1.1	0.3	0.2	0	37.8	21.5	0	123	84	0	35	34	34	
2025	11	16	17	2	15	26.3	-1.6	1.1	0.3	0.2	0	37.4	21.1	0	122	82	0	35	33	34	
2025	11	16	17	12	15	24.8	-2.4	1.1	0.5	0.4	0	37.8	21.5	0	123	84	0	35	34	34	
2025	11	16	17	22	15	26.3	-2.1	1.101	0.4	0.3	0	38.3	21.1	0	124	83	0	35	34	34	
2025	11	16	17	32	15	25	-0.9	1.101	0.3	0.2	0	37.8	21.1	0	123	82	0	35	33	34	
2025	11	16	17	42	15	26.7	-2	1.1	0.4	0.3	0	37.4	20.2	0	122	80	0	35	33	34	
2025	11	16	17	52	15	25	-1.4	1.1	0.3	0.2	0	38.3	19.4	0	123	79	0	34	34	34	
2025	11	16	18	2	15	24.2	-1.4	1.1	0.4	0.3	0	37.8	19.4	0	123	78	0	35	33	34	
2025	11	16	18	12	15	26.6	-1.7	1.1	0.4	0.3	0	37.8	18.5	0	122	77	0	34	34	34	
2025	11	16	18	22	15	26.5	-1.7	1.1	0.4	0.3	0	37.4	18.5	0	122	76	0	35	33	34	
2025	11	16	18	32	15	25.9	-1.8	1.1	0.3	0.2	0	38.3	18.9	0	124	77	0	35	33	34	
2025	11	16	18	42	15	26	-2.6	1.1	0.4	0.3	0	38.7	19.4	0	125	78	0	35	33	34	
2025	11	16	18	52	15	26.1	-2.2	1.1	0.4	0.3	0	38.3	19.4	0	124	78	0	35	33	34	
2025	11	16	19	2	15	25.9	-1.8	1.1	0.4	0.3	0	39.1	19.8	0	125	79	0	34	33	35	
2025	11	16	19	12	15	26.3	-2.4	1.1	0.3	0.2	0	38.7	19.8	0	125	79	0	35	33	35	
2025	11	16	19	22	15	25.6	-2.2	1.1	0.3	0.2	0	38.3	19.8	0	124	80	0	35	34	34	
2025	11	16	19	32	15	24.6	-2.1	1.1	0.4	0.3	0	38.3	19.4	0	124	79	0	35	34	34	
2025	11	16	19	42	15	25.6	-2.1	1.1	0.4	0.3	0	38.3	19.8	0	124	79	0	35	33	34	
2025	11	16	19	52	15	24.9	-1	1.1	0.3	0.2	0	37.8	18.9	0	123	77	0	35	33	34	
2025	11	16	20	2	15	26.5	-1.5	1.1	0.3	0.2	0	38.3	19.8	0	124	79	0	35	33	34	
2025	11	16	20	12	15	26	-1.5	1.1	0.5	0.4	0	38.3	19.8	0	124	79	0	35	33	35	
2025	11	16	20	22	15	25.8	-2.3	1.1	0.4	0.3	0	38.7	20.2	0	125	80	0	35	33	34	
2025	11	16	20	32	15	26.7	-2.2	1.101	0.4	0.3	0	38.7	18.9	0	124	78	0	34	34	34	
2025	11	16	20	42	15	25.1	-2.2	1.1	0.3	0.2	0	38.3	19.8	0	124	80	0	35	34	34	
2025	11	16	20	52	15	25.6	-1.7	1.1	0.5	0.5	0	38.3	19.8	0	124	79	0	35	33	35	
2025	11	16	21	2	15	25.8	-1.4	1.1	0.3	0.2	0	38.3	19.8	0	124	79	0	35	33	34	
2025	11	16	21	12	15	26.5	-1.3	1.1	0.3	0.2	0	38.3	19.4	0	124	79	0	35	34	34	
2025	11	16	21	22	15	25.2	-1.5	1.101	0.4	0.3	0	38.3	19.8	0	123	79	0	34	33	35	
2025	11	16	21	32	15	24.8	-1.7	1.101	0.4	0.3	0	38.7	19.4	0	124	78	0	34	33	34	
2025	11	16	21	42	15	24.4	-1.3	1.101	0.4	0.3	0	38.3	18.5	0	123	77	0	34	34	34	
2025	11	16	21	52	15	26.3	-2.3	1.101	0.4	0.3	0	38.7	20.2	0	125	80	0	35	33	34	
2025	11	16	22	2	15	24.6	-1.3	1.101	0.4	0.3	0	38.3	19.8	0	124	80	0	35	34	34	
2025	11	16	22	12	15	25.2	-1.5	1.101	0.3	0.2	0	38.7	19.8	0	125	80	0	35	34	34	
2025	11	16	22	22	15	25.9	-1.7	1.101	0.4	0.3	0	38.3	19.8	0	124	79	0	35	33	34	
2025	11	16	22	32	15	25.5	-3.8	1.101	0.5	0.4	0	35.3	19.4	0	116	79	0	34	34	35	
2025	11	16	22	42	15	24.1	-0.9	1.101	0.3	0.2	0	39.1	19.8	0	125	80	0	34	34	34	
2025	11	16	22	52	15	25.1	-0.9	1.101	0.5	0.4	0	39.1	20.2	0	125	80	0	34	33	34	
2025	11	16	23	2	15	24.5	-0.6	1.101	0.4	0.3	0	38.3	20.2	0	124	80	0	35	33	34	
2025	11	16	23	12	15	24.5	-0.8	1.101	0.3	0.2	0	38.3	20.6	0	124	81	0	35	33	34	
2025	11	16	23	22	15	26.8	-2.5	1.101	0.3	0.2	0	38.3	19.8	0	124	79	0	35	33	34	
2025	11	16	23	32	15	24.6	-0.9	1.101	0.4	0.3	0	38.7	19.4	0	125	78	0	35	33	34	
2025	11	16	23	42	15	25.5	-1.5	1.101	0.3	0.2	0	38.3	20.2	0	124	80	0	35	33	35	
2025	11	16	23	52	15	23.7	-1.5	1.101	0.3	0.2	0	38.7	19.4	0	125	79	0	35	34	34	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	17	0	2	15	26.3	-2.1	1.101	0.3	0.2	0	38.3	20.2	0	124	81	0	35	34	34
2025	11	17	0	12	15	25.1	-2.6	1.101	0.3	0.2	0	38.7	20.2	0	125	80	0	35	33	34
2025	11	17	0	22	15	25.8	-2.5	1.101	0.5	0.4	0	38.7	20.2	0	124	80	0	34	33	35
2025	11	17	0	32	15	26.7	-2.5	1.101	0.5	0.4	0	38.3	19.8	0	124	79	0	35	33	34
2025	11	17	0	42	15	25.8	-1.4	1.101	0.3	0.2	0	38.7	18.9	0	124	77	0	34	33	34
2025	11	17	0	52	15	26.2	-1.9	1.101	0.3	0.2	0	38.3	18.9	0	124	78	0	35	34	35
2025	11	17	1	2	15	25.3	-1.3	1.101	0.5	0.4	0	38.7	20.2	0	125	80	0	35	33	35
2025	11	17	1	12	15	25.7	-2.6	1.101	0.4	0.3	0	40.9	21.5	0	129	84	0	34	34	34
2025	11	17	1	22	15	26.5	-3	1.102	0.4	0.3	0	39.6	21.1	0	127	83	0	35	34	35
2025	11	17	1	32	15	26.8	-2.3	1.101	0.4	0.3	0	39.6	20.2	0	126	81	0	34	34	34
2025	11	17	1	42	15	27.1	-2.6	1.102	0.4	0.3	0	38.3	20.2	0	124	80	0	35	33	34
2025	11	17	1	52	15	25.7	-1.8	1.102	0.5	0.4	0	39.1	20.2	0	125	80	0	34	33	34
2025	11	17	2	2	15	25.8	-1.5	1.102	0.3	0.2	0	39.6	20.2	0	127	81	0	35	34	35
2025	11	17	2	12	15	24.9	-2.7	1.101	0.4	0.3	0	40.4	21.1	0	129	82	0	35	33	35
2025	11	17	2	22	15	26.6	-1.7	1.101	0.3	0.2	0	39.1	19.4	0	126	79	0	35	34	34
2025	11	17	2	32	15	25.4	-1.2	1.102	0.4	0.3	0	39.1	18.9	0	126	78	0	35	34	34
2025	11	17	2	42	15	25.3	-0.8	1.102	0.3	0.2	0	39.1	18.9	0	125	77	0	34	33	34
2025	11	17	2	52	15	25.2	-0.8	1.102	0.4	0.3	0	38.7	18.5	0	125	77	0	35	34	34
2025	11	17	3	2	15	25.3	-2.6	1.102	0.3	0.2	0	38.7	19.8	0	125	79	0	35	33	35
2025	11	17	3	12	15	24.6	-1.4	1.102	0.3	0.2	0	38.7	19.4	0	125	78	0	35	33	34
2025	11	17	3	22	15	25.7	-1.9	1.102	0.4	0.3	0	38.3	18.9	0	124	78	0	35	34	34
2025	11	17	3	32	15	25.3	-2	1.102	0.5	0.4	0	37.8	19.8	0	123	79	0	35	33	34
2025	11	17	3	42	15	26	-2	1.102	0.3	0.2	0	38.7	18.9	0	125	78	0	35	34	34
2025	11	17	3	52	15	26.3	-2.5	1.102	0.4	0.3	0	38.7	19.8	0	124	79	0	34	33	34
2025	11	17	4	2	15	25.2	-2.5	1.102	0.5	0.4	0	38.7	18.9	0	125	78	0	35	34	35
2025	11	17	4	12	15	25.6	-1.6	1.102	0.5	0.4	0	38.7	18.1	0	124	76	0	34	34	35
2025	11	17	4	22	15	25.7	-0.8	1.102	0.5	0.4	0	38.7	19.8	0	125	79	0	35	33	34
2025	11	17	4	32	15	26.5	-1.7	1.102	0.4	0.3	0	38.3	18.9	0	124	78	0	35	34	34
2025	11	17	4	42	15	25.4	-1.9	1.104	0.3	0.2	0	38.7	18.5	0	125	77	0	35	34	35
2025	11	17	4	52	15	25.4	-2.1	1.103	0.4	0.3	0	38.3	18.5	0	124	77	0	35	34	34
2025	11	17	5	2	15	25.2	-1.7	1.102	0.3	0.2	0	38.3	18.9	0	124	77	0	35	33	34
2025	11	17	5	12	15	24.8	-1.4	1.103	0.4	0.3	0	38.7	18.9	0	124	77	0	34	33	35
2025	11	17	5	22	15	24.9	-0.4	1.103	0.4	0.3	0	37.8	19.8	0	123	79	0	35	33	34
2025	11	17	5	32	15	26.4	-0.3	1.103	0.4	0.3	0	38.7	18.9	0	125	78	0	35	34	35
2025	11	17	5	42	15	24.2	-0.2	1.103	0.4	0.3	0	38.3	19.4	0	124	78	0	35	33	34
2025	11	17	5	52	15	26.1	-1.6	1.103	0.3	0.2	0	38.3	18.9	0	124	78	0	35	34	34
2025	11	17	6	2	15	25.2	-2	1.103	0.3	0.2	0	38.7	19.4	0	125	79	0	35	34	34
2025	11	17	6	12	15	25.6	-1.7	1.104	0.3	0.2	0	38.3	19.8	0	124	79	0	35	33	34
2025	11	17	6	22	15	25.5	-2.1	1.104	0.3	0.2	0	38.7	18.5	0	124	77	0	34	34	34
2025	11	17	6	32	15	26.1	-2.3	1.104	0.3	0.2	0	38.3	18.9	0	124	77	0	35	33	35
2025	11	17	6	42	15	25.2	-0.9	1.105	0.3	0.2	0	38.3	18.9	0	124	77	0	35	33	34
2025	11	17	6	52	15	25.6	-1.2	1.104	0.4	0.3	0	38.7	19.4	0	125	78	0	35	33	35
2025	11	17	7	2	15	26	-2.6	1.104	0.4	0.3	0	38.3	18.9	0	124	77	0	35	33	34
2025	11	17	7	12	15	26	-2.1	1.104	0.4	0.3	0	37.8	18.5	0	123	77	0	35	34	34
2025	11	17	7	22	15	24.7	-1.4	1.104	0.4	0.3	0	39.1	19.8	0	126	79	0	35	33	35
2025	11	17	7	32	15	24.6	-2.1	1.104	0.4	0.3	0	38.7	18.5	0	124	77	0	34	34	35
2025	11	17	7	42	15	26	-0.8	1.104	0.4	0.3	0	38.3	18.9	0	124	78	0	35	34	35
2025	11	17	7	52	15	26.5	-0.4	1.104	0.3	0.2	0	37.8	18.1	0	123	76	0	35	34	35

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	11	17	8	2	15	24.6	-1.6	1.104	0.3	0.2	0	38.3	18.5	0	124	77	0	35	34	34	
2025	11	17	8	12	15	25.8	-2.3	1.103	0.4	0.3	0	37.8	18.1	0	123	76	0	35	34	34	
2025	11	17	8	22	15	25.8	-2.3	1.104	0.4	0.3	0	37.8	18.5	0	123	76	0	35	33	35	
2025	11	17	8	32	15	25.6	-0.8	1.104	0.4	0.3	0	37	17.2	0	121	74	0	35	34	34	
2025	11	17	8	42	15	25.3	-1.7	1.104	0.3	0.2	0	37.8	18.5	0	122	76	0	34	33	34	
2025	11	17	8	52	15	23.6	-0.9	1.104	0.3	0.2	0	36.5	18.5	0	120	77	0	35	34	34	
2025	11	17	9	2	15	24.5	-0.5	1.103	0.3	0.2	0	37	18.9	0	121	77	0	35	33	34	
2025	11	17	9	12	15	25.1	-0.7	1.103	0.3	0.2	0	37.4	18.5	0	122	77	0	35	34	34	
2025	11	17	9	22	15	25.1	-2.1	1.103	0.5	0.4	0	37.4	18.5	0	122	77	0	35	34	35	
2025	11	17	9	32	15	24.6	-2.1	1.103	0.4	0.3	0	37	18.9	0	121	77	0	35	33	35	
2025	11	17	9	42	15	24.1	-1.9	1.103	0.3	0.2	0	36.5	18.1	0	120	75	0	35	33	34	
2025	11	17	9	52	15	26.7	-2.1	1.102	0.3	0.2	0	36.5	18.5	0	120	76	0	35	33	35	
2025	11	17	10	2	15	26.1	-3.1	1.102	0.4	0.3	0	36.5	18.5	0	120	76	0	35	33	35	
2025	11	17	10	12	15	24.9	-2.4	1.102	0.3	0.2	0	36.1	17.6	0	119	75	0	35	34	34	
2025	11	17	10	22	15	25.5	-1.8	1.102	0.3	0.2	0	36.1	18.5	0	119	76	0	35	33	34	
2025	11	17	10	32	15	25.4	-2.2	1.102	0.3	0.2	0	35.7	17.6	0	118	75	0	35	34	35	
2025	11	17	10	42	15	25.7	-1.4	1.101	0.3	0.2	0	36.5	18.1	0	119	76	0	34	34	34	
2025	11	17	10	52	15	25	-2.3	1.101	0.5	0.4	0	36.1	18.1	0	119	75	0	35	33	35	
2025	11	17	11	2	15	26.3	-2	1.101	0.4	0.3	0	36.1	18.1	0	119	75	0	35	33	34	
2025	11	17	11	12	15	25.3	-2.3	1.101	0.5	0.4	0	37	17.6	0	120	75	0	34	34	34	
2025	11	17	11	22	15	23.4	-1.3	1.101	0.4	0.3	0	37	18.1	0	120	76	0	34	34	35	
2025	11	17	11	32	15	24.7	-1.2	1.101	0.4	0.3	0	36.1	17.6	0	119	75	0	35	34	34	
2025	11	17	11	42	15	25.2	-2.3	1.101	0.4	0.3	0	35.7	17.6	0	118	74	0	35	33	34	
2025	11	17	11	52	15	25.7	-2.1	1.101	0.3	0.2	0	36.1	18.1	0	119	76	0	35	34	34	
2025	11	17	12	2	15	24.7	-0.4	1.101	0.5	0.4	0	35.7	18.1	0	118	75	0	35	33	34	
2025	11	17	12	12	15	24.4	-2.9	1.1	0.3	0.2	0	36.1	17.6	0	118	75	0	34	34	34	
2025	11	17	12	22	15	24.1	-1.7	1.101	0.3	0.2	0	35.7	18.1	0	118	75	0	35	33	34	
2025	11	17	12	32	15	23.5	-0.7	1.101	0.3	0.2	0	35.7	17.6	0	118	75	0	35	34	34	
2025	11	17	12	42	15	24.9	-1.4	1.1	0.5	0.5	0	36.5	18.1	0	120	76	0	35	34	34	
2025	11	17	12	52	15	23.5	-0.7	1.1	0.3	0.2	0	37	18.9	0	121	77	0	35	33	35	
2025	11	17	13	2	15	24.8	-2	1.1	0.3	0.2	0	36.5	18.9	0	120	77	0	35	33	34	
2025	11	17	13	12	15	23.4	-1.8	1.101	0.3	0.2	0	37.4	19.4	0	121	78	0	34	33	34	
2025	11	17	13	22	15	24.8	-1.2	1.101	0.3	0.2	0	37.4	18.9	0	122	78	0	35	34	35	
2025	11	17	13	32	15	24.1	-1.4	1.1	0.3	0.2	0	37.4	18.9	0	122	78	0	35	34	33	
2025	11	17	13	42	15	24.4	-1.2	1.099	0.4	0.3	0	37	18.5	0	121	77	0	35	34	35	
2025	11	17	13	52	15	24.8	-0.8	1.1	0.3	0.2	0	37.4	18.9	0	121	78	0	34	34	35	
2025	11	17	14	2	15	25.2	-1.2	1.1	0.5	0.4	0	37	18.9	0	121	78	0	35	34	34	
2025	11	17	14	12	15	25.9	-2.7	1.1	0.4	0.3	0	37.4	18.5	0	121	77	0	34	34	35	
2025	11	17	14	22	15	23.7	-0.5	1.1	0.3	0.2	0	37	19.4	0	121	78	0	35	33	34	
2025	11	17	14	32	15	23.9	-1.8	1.101	0.3	0.2	0	36.5	18.5	0	120	77	0	35	34	35	
2025	11	17	14	42	15	24.3	-1.6	1.1	0.3	0.2	0	36.5	18.5	0	120	77	0	35	34	34	
2025	11	17	14	52	15	24.8	-1.5	1.1	0.4	0.3	0	37.4	18.5	0	121	77	0	34	34	35	
2025	11	17	15	2	15	24.7	-2.3	1.099	0.3	0.2	0	37.4	18.5	0	121	77	0	34	34	35	
2025	11	17	15	12	15	25.9	-2.2	1.099	0.3	0.2	0	36.5	18.1	0	120	76	0	35	34	34	
2025	11	17	15	22	15	24	-1.5	1.098	0.5	0.4	0	36.5	18.5	0	120	77	0	35	34	34	
2025	11	17	15	32	15	24.7	-0.4	1.099	0.3	0.2	0	36.5	18.5	0	120	76	0	35	33	34	
2025	11	17	15	42	15	24.9	-2.7	1.099	0.4	0.3	0	36.5	18.1	0	120	76	0	35	34	35	
2025	11	17	15	52	15	24.1	-0.8	1.098	0.5	0.4	0	36.5	18.1	0	120	76	0	35	34	34	

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	11	17	16	2	15	24.8	0	1.097	0.5	0.4	0	36.5	18.5	0	120	77	0	35	34	35	
2025	11	17	16	12	15	23.5	-0.7	1.098	0.5	0.4	0	37	18.5	0	121	77	0	35	34	34	
2025	11	17	16	22	15	24.6	-0.1	1.098	0.3	0.2	0	37	18.9	0	121	78	0	35	34	34	
2025	11	17	16	32	15	23.5	-0.8	1.097	0.3	0.2	0	37.4	19.4	0	122	79	0	35	34	34	
2025	11	17	16	42	15	25.5	-1.5	1.099	0.3	0.2	0	38.3	19.4	0	123	79	0	34	34	35	
2025	11	17	16	52	15	23.1	-1.3	1.098	0.4	0.3	0	37.8	19.4	0	122	79	0	34	34	34	
2025	11	17	17	2	15	24.2	-1.5	1.096	0.5	0.4	0	37	19.4	0	121	78	0	35	33	35	
2025	11	17	17	12	15	24.7	-1.5	1.096	0.4	0.3	0	37.4	19.4	0	122	79	0	35	34	34	
2025	11	17	17	22	15	26	-1	1.098	0.3	0.2	0	37.4	18.9	0	122	78	0	35	34	34	
2025	11	17	17	32	15	23.5	-1.7	1.096	0.3	0.2	0	37.8	19.4	0	123	79	0	35	34	35	
2025	11	17	17	42	15	23.3	-0.9	1.096	0.3	0.2	0	37.8	19.8	0	123	79	0	35	33	34	
2025	11	17	17	52	15	24.2	-1.7	1.098	0.5	0.4	0	38.3	19.8	0	123	80	0	34	34	35	
2025	11	17	18	2	15	25	-1.3	1.097	0.4	0.3	0	38.3	19.4	0	123	79	0	34	34	35	
2025	11	17	18	12	15	23.9	-1.6	1.098	0.4	0.3	0	38.3	19.4	0	123	79	0	34	34	34	
2025	11	17	18	22	15	24.1	-1.2	1.095	0.3	0.2	0	37.8	18.9	0	123	78	0	35	34	35	
2025	11	17	18	32	15	25.3	-1.2	1.095	0.5	0.4	0	37.8	18.9	0	123	78	0	35	34	35	
2025	11	17	18	42	15	24.8	-1.5	1.096	0.3	0.2	0	37.4	18.9	0	122	78	0	35	34	34	
2025	11	17	18	52	15	24.6	-1.6	1.096	0.3	0.2	0	38.3	18.9	0	124	78	0	35	34	35	
2025	11	17	19	2	15	24.9	-1.1	1.096	0.4	0.3	0	37.8	19.4	0	123	78	0	35	33	34	
2025	11	17	19	12	15	24.5	-1.7	1.093	0.3	0.2	0	39.1	19.8	0	126	80	0	35	34	34	
2025	11	17	19	22	15	25.2	-1.4	1.095	0.4	0.3	0	37.8	18.5	0	123	77	0	35	34	35	
2025	11	17	19	32	15	25.6	-1.1	1.094	0.5	0.4	0	38.7	19.4	0	124	79	0	34	34	34	
2025	11	17	19	42	15	24.7	-1.2	1.095	0.3	0.2	0	38.3	19.4	0	124	79	0	35	34	34	
2025	11	17	19	52	15	25	0	1.095	0.3	0.2	0	39.1	19.8	0	126	80	0	35	34	34	
2025	11	17	20	2	15	24.8	-2.1	1.095	0.4	0.3	0	40.4	21.1	0	129	83	0	35	34	35	
2025	11	17	20	12	15	25.5	-2.9	1.095	0.4	0.3	0	39.1	20.2	0	126	81	0	35	34	35	
2025	11	17	20	22	15	26.9	-2.3	1.095	0.4	0.3	0	39.6	20.2	0	127	81	0	35	34	35	
2025	11	17	20	32	15	25.1	-1.6	1.095	0.4	0.3	0	39.1	19.8	0	125	79	0	34	33	33	
2025	11	17	20	42	15	25	-2.3	1.096	0.3	0.2	0	40.4	21.1	0	129	83	0	35	34	34	
2025	11	17	20	52	15	26	-0.9	1.095	0.4	0.3	0	40.4	21.1	0	129	83	0	35	34	35	
2025	11	17	21	2	15	24.8	-2	1.096	0.4	0.3	0	39.1	19.8	0	126	80	0	35	34	34	
2025	11	17	21	12	15	25.1	-1.6	1.096	0.3	0.2	0	40	21.1	0	128	82	0	35	33	35	
2025	11	17	21	22	15	25.9	-0.9	1.097	0.4	0.3	0	40.9	21.5	0	130	84	0	35	34	35	
2025	11	17	21	32	15	25.4	-1.4	1.097	0.4	0.3	0	41.7	22.4	0	132	86	0	35	34	34	
2025	11	17	21	42	15	25.5	-2	1.098	0.3	0.2	0	40.4	21.1	0	129	83	0	35	34	34	
2025	11	17	21	52	15	25	-0.8	1.098	0.4	0.3	0	40	20.6	0	128	82	0	35	34	34	
2025	11	17	22	2	15	24.6	-2.7	1.098	0.3	0.2	0	40	21.1	0	128	82	0	35	33	35	
2025	11	17	22	12	15	25.4	-1.7	1.098	0.4	0.3	0	40	20.6	0	128	82	0	35	34	34	
2025	11	17	22	22	15	26.7	-2.1	1.098	0.4	0.3	0	42.6	23.2	0	134	87	0	35	33	35	
2025	11	17	22	32	15	25.3	-1.6	1.101	0.3	0.2	0	40.4	21.9	0	129	84	0	35	33	34	
2025	11	17	22	42	15	26.4	-2	1.1	0.4	0.3	0	40.4	21.5	0	129	84	0	35	34	34	
2025	11	17	22	52	15	24.7	-1.1	1.101	0.3	0.2	0	40.4	21.1	0	129	83	0	35	34	35	
2025	11	17	23	2	15	26.7	-1.7	1.101	0.4	0.3	0	40.4	21.1	0	129	82	0	35	33	34	
2025	11	17	23	12	15	26.2	-1.6	1.102	0.5	0.4	0	40	20.6	0	128	82	0	35	34	34	
2025	11	17	23	22	15	25.4	-2.1	1.102	0.3	0.2	0	40	21.1	0	128	83	0	35	34	35	
2025	11	17	23	32	15	25.4	-2.5	1.103	0.3	0.2	0	39.6	20.2	0	127	81	0	35	34	35	
2025	11	17	23	42	15	25.2	-1.7	1.103	0.3	0.2	0	39.1	20.6	0	126	81	0	35	33	34	
2025	11	17	23	52	15	26.3	-1.6	1.104	0.3	0.2	0	38.7	20.2	0	125	80	0	35	33	35	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	18	0	2	15	26.1	-2	1.104	0.3	0.2	0	39.6	20.2	0	126	80	0	34	33	34
2025	11	18	0	12	15	24.7	-2.1	1.104	0.3	0.2	0	39.1	19.4	0	125	79	0	34	34	35
2025	11	18	0	22	15	24.8	-2.6	1.103	0.3	0.2	0	38.7	19.4	0	124	79	0	34	34	34
2025	11	18	0	32	15	24.3	-0.8	1.105	0.4	0.3	0	38.3	19.4	0	124	79	0	35	34	34
2025	11	18	0	42	15	24.6	-1.8	1.105	0.4	0.3	0	38.3	18.9	0	124	78	0	35	34	35
2025	11	18	0	52	15	25.8	-1.8	1.105	0.4	0.3	0	38.3	18.9	0	124	78	0	35	34	35
2025	11	18	1	2	15	25.8	-0.8	1.106	0.3	0.2	0	37.8	18.9	0	123	78	0	35	34	34
2025	11	18	1	12	15	26.4	-1.3	1.107	0.5	0.5	0	37.8	18.5	0	123	76	0	35	33	34
2025	11	18	1	22	15	26.1	-1.8	1.107	0.4	0.3	0	37.8	18.5	0	123	77	0	35	34	34
2025	11	18	1	32	15	25.7	-2.9	1.107	0.3	0.2	0	37.8	18.1	0	122	76	0	34	34	34
2025	11	18	1	42	15	26.3	-0.7	1.107	0.3	0.2	0	37.8	18.1	0	123	76	0	35	34	35
2025	11	18	1	52	15	24.7	-1.4	1.107	0.3	0.2	0	37.4	18.5	0	122	77	0	35	34	35
2025	11	18	2	2	15	25.5	-2.5	1.107	0.3	0.2	0	37.8	18.1	0	123	76	0	35	34	35
2025	11	18	2	12	15	25.2	-0.8	1.107	0.3	0.2	0	37.8	18.1	0	122	76	0	34	34	35
2025	11	18	2	22	15	24.8	-0.8	1.108	0.4	0.3	0	37.4	18.5	0	122	76	0	35	33	34
2025	11	18	2	32	15	25.6	-1.8	1.108	0.3	0.2	0	37.8	18.1	0	122	76	0	34	34	35
2025	11	18	2	42	15	25.9	-1.3	1.108	0.3	0.2	0	37.8	18.1	0	123	76	0	35	34	35
2025	11	18	2	52	15	24.7	-0.6	1.108	0.3	0.2	0	37.4	18.9	0	122	77	0	35	33	35
2025	11	18	3	2	15	25.8	-2	1.108	0.5	0.4	0	37.4	18.5	0	122	76	0	35	33	35
2025	11	18	3	12	15	26.2	-0.8	1.108	0.4	0.3	0	37.8	18.1	0	123	76	0	35	34	35
2025	11	18	3	22	15	26.7	-0.8	1.109	0.4	0.3	0	37.4	18.1	0	122	76	0	35	34	35
2025	11	18	3	32	15	25.4	-2.1	1.109	0.4	0.3	0	37	17.6	0	121	75	0	35	34	34
2025	11	18	3	42	15	26	-0.9	1.109	0.3	0.2	0	37	17.6	0	121	75	0	35	34	34
2025	11	18	3	52	15	25.7	-1.9	1.109	0.4	0.3	0	37.4	17.6	0	121	75	0	34	34	34
2025	11	18	4	2	15	25	-2	1.109	0.4	0.3	0	37.4	17.6	0	122	75	0	35	34	34
2025	11	18	4	12	15	25.8	-2.5	1.109	0.4	0.3	0	37.8	17.6	0	122	75	0	34	34	35
2025	11	18	4	22	15	26.7	-1.7	1.108	0.3	0.2	0	38.3	18.9	0	124	77	0	35	33	35
2025	11	18	4	32	15	24.6	-1.6	1.109	0.3	0.2	0	37.8	18.9	0	123	77	0	35	33	35
2025	11	18	4	42	15	25	-1.6	1.109	0.3	0.2	0	37.8	18.1	0	123	76	0	35	34	34
2025	11	18	4	52	15	25.2	-1.4	1.109	0.4	0.3	0	37.4	18.9	0	122	78	0	35	34	34
2025	11	18	5	2	15	26.1	-1.2	1.109	0.4	0.3	0	37.8	18.5	0	123	77	0	35	34	34
2025	11	18	5	12	15	25.4	-1.4	1.109	0.3	0.2	0	37.8	18.5	0	123	77	0	35	34	34
2025	11	18	5	22	15	24.9	-0.9	1.109	0.4	0.3	0	37.4	18.9	0	122	78	0	35	34	34
2025	11	18	5	32	15	26	-2	1.109	0.4	0.3	0	37.8	18.1	0	122	76	0	34	34	35
2025	11	18	5	42	15	24.6	-0.9	1.109	0.3	0.2	0	37.4	18.5	0	122	76	0	35	33	35
2025	11	18	5	52	15	25.5	-1.2	1.109	0.4	0.3	0	37	18.1	0	121	76	0	35	34	35
2025	11	18	6	2	15	27	-1.7	1.109	0.4	0.3	0	37.4	18.5	0	122	77	0	35	34	34
2025	11	18	6	12	15	24.9	-0.8	1.109	0.4	0.3	0	37.4	18.1	0	122	76	0	35	34	34
2025	11	18	6	22	15	25	-0.3	1.109	0.5	0.4	0	37	18.1	0	121	76	0	35	34	34
2025	11	18	6	32	15	25.6	-0.8	1.109	0.3	0.2	0	37.4	18.1	0	121	76	0	34	34	35
2025	11	18	6	42	15	25.6	-1.6	1.109	0.5	0.4	0	37	17.6	0	121	76	0	35	35	34
2025	11	18	6	52	15	25.2	-0.8	1.109	0.3	0.2	0	36.5	17.6	0	120	75	0	35	34	35
2025	11	18	7	2	15	26.1	-0.2	1.109	0.3	0.2	0	36.1	17.6	0	119	75	0	35	34	35
2025	11	18	7	12	15	26	-1.4	1.109	0.3	0.2	0	36.5	18.1	0	120	76	0	35	34	35
2025	11	18	7	22	15	25.4	-0.8	1.109	0.4	0.3	0	36.1	18.5	0	118	77	0	34	34	35
2025	11	18	7	32	15	25.1	-2	1.109	0.4	0.3	0	36.1	18.9	0	119	78	0	35	34	34
2025	11	18	7	42	15	25	-1.7	1.109	0.4	0.3	0	35.7	18.9	0	118	78	0	35	34	35
2025	11	18	7	52	15	24.9	-1.6	1.109	0.4	0.3	0	35.3	17.6	0	117	75	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	18	8	2	15	25.5	-1.6	1.109	0.3	0.2	0	35.7	17.6	0	118	75	0	35	34	34
2025	11	18	8	12	15	25.4	-1.4	1.109	0.4	0.3	0	35.7	17.6	0	118	75	0	35	34	34
2025	11	18	8	22	15	26.2	-1.2	1.109	0.3	0.2	0	35.3	17.6	0	117	75	0	35	34	35
2025	11	18	8	32	15	25.5	-1.1	1.109	0.3	0.2	0	35.3	18.1	0	117	75	0	35	33	34
2025	11	18	8	42	15	25	-0.8	1.109	0.3	0.2	0	34.8	17.2	0	116	74	0	35	34	35
2025	11	18	8	52	15	25.4	-1.3	1.109	0.4	0.3	0	34.8	18.1	0	116	75	0	35	33	35
2025	11	18	9	2	15	24.5	-0.7	1.109	0.3	0.2	0	35.3	18.1	0	117	76	0	35	34	35
2025	11	18	9	12	15	24.8	0	1.109	0.4	0.3	0	34.8	18.1	0	116	75	0	35	33	35
2025	11	18	9	22	15	25	-1.9	1.109	0.3	0.2	0	34.8	17.2	0	116	74	0	35	34	35
2025	11	18	9	32	15	24.5	-2.1	1.109	0.4	0.3	0	34.8	17.2	0	116	74	0	35	34	35
2025	11	18	9	42	15	24.5	-2	1.109	0.4	0.3	0	34.4	16.8	0	115	73	0	35	34	34
2025	11	18	9	52	15	24.4	-0.9	1.109	0.3	0.2	0	34.4	17.6	0	115	75	0	35	34	34
2025	11	18	10	2	15	24.1	-1.9	1.109	0.4	0.3	0	34.4	17.2	0	115	74	0	35	34	35
2025	11	18	10	12	15	23.7	-0.8	1.109	0.4	0.3	0	34.4	17.6	0	115	74	0	35	33	35
2025	11	18	10	22	15	25.2	-2.5	1.109	0.5	0.4	0	34.4	17.2	0	115	74	0	35	34	35
2025	11	18	10	32	15	25.4	-1.7	1.108	0.4	0.3	0	34.8	18.5	0	116	76	0	35	33	35
2025	11	18	10	42	15	24.7	-1.7	1.109	0.3	0.2	0	34.8	18.1	0	116	75	0	35	33	34
2025	11	18	10	52	15	26.9	-1.5	1.109	0.3	0.2	0	33.5	17.2	0	114	74	0	36	34	35
2025	11	18	11	2	15	24.5	-2	1.109	0.4	0.3	0	34.4	17.6	0	115	74	0	35	33	35
2025	11	18	11	12	15	24.7	-1.4	1.108	0.3	0.2	0	34.8	17.6	0	115	74	0	34	33	35
2025	11	18	11	22	15	25.6	-1.5	1.108	0.4	0.3	0	34	16.8	0	114	73	0	35	34	34
2025	11	18	11	32	15	25.4	-2.1	1.108	0.5	0.5	0	34.4	17.6	0	115	75	0	35	34	34
2025	11	18	11	42	15	24	-1.6	1.109	0.4	0.3	0	34.4	18.1	0	115	75	0	35	33	35
2025	11	18	11	52	15	24.2	-1.4	1.109	0.4	0.3	0	34.8	18.1	0	116	76	0	35	34	35
2025	11	18	12	2	15	24.2	-0.8	1.109	0.3	0.2	0	34.8	17.6	0	116	75	0	35	34	35
2025	11	18	12	12	15	24.3	-1.5	1.109	0.4	0.3	0	34.4	17.6	0	115	75	0	35	34	34
2025	11	18	12	22	15	24.9	-1.4	1.109	0.4	0.3	0	34.8	18.1	0	116	76	0	35	34	35
2025	11	18	12	32	15	24.5	-2	1.108	0.3	0.2	0	34.8	18.9	0	116	77	0	35	33	34
2025	11	18	12	42	15	23.5	-0.8	1.109	0.3	0.2	0	34.4	17.6	0	115	75	0	35	34	34
2025	11	18	12	52	15	24.3	-1.2	1.108	0.3	0.2	0	34.4	17.6	0	115	75	0	35	34	34
2025	11	18	13	2	15	24.6	-2	1.108	0.4	0.3	0	34.8	18.5	0	116	76	0	35	33	34
2025	11	18	13	12	15	25	-1.6	1.108	0.3	0.2	0	36.1	19.4	0	119	79	0	35	34	34
2025	11	18	13	22	15	24.4	-1.4	1.108	0.4	0.3	0	36.1	19.8	0	119	79	0	35	33	34
2025	11	18	13	32	15	25.4	-1.7	1.108	0.4	0.3	0	35.3	18.5	0	117	77	0	35	34	35
2025	11	18	13	42	15	23.7	-1.9	1.108	0.3	0.2	0	35.3	18.5	0	117	77	0	35	34	34
2025	11	18	13	52	15	25.3	-1.8	1.108	0.3	0.2	0	35.3	18.5	0	117	77	0	35	34	34
2025	11	18	14	2	15	24.7	-1.6	1.109	0.3	0.2	0	34.8	18.1	0	116	76	0	35	34	35
2025	11	18	14	12	15	23.9	-1.9	1.108	0.3	0.2	0	34.4	17.6	0	115	75	0	35	34	34
2025	11	18	14	22	15	23.4	-1.1	1.108	0.3	0.2	0	35.3	18.5	0	117	77	0	35	34	35
2025	11	18	14	32	15	24.4	-2.4	1.109	0.4	0.3	0	35.7	18.9	0	118	78	0	35	34	35
2025	11	18	14	42	15	25.3	-2.6	1.109	0.4	0.3	0	36.5	19.4	0	120	79	0	35	34	35
2025	11	18	14	52	15	24.3	-2.5	1.109	0.4	0.3	0	36.5	19.4	0	120	79	0	35	34	35
2025	11	18	15	2	15	24.4	-2.1	1.109	0.3	0.2	0	37	20.2	0	121	80	0	35	33	34
2025	11	18	15	12	15	25	-1.4	1.109	0.4	0.3	0	37	19.4	0	121	79	0	35	34	35
2025	11	18	15	22	15	24.9	-1.5	1.109	0.5	0.4	0	37	20.2	0	121	81	0	35	34	35
2025	11	18	15	32	15	24.9	-1.6	1.109	0.3	0.2	0	36.5	19.8	0	120	80	0	35	34	34
2025	11	18	15	42	15	25	-1.1	1.11	0.5	0.4	0	36.1	19.4	0	119	79	0	35	34	34
2025	11	18	15	52	15	25.8	-0.7	1.11	0.4	0.3	0	36.1	19.8	0	119	79	0	35	33	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	18	16	2	15	25.6	-1.6	1.11	0.4	0.3	0	35.7	18.9	0	118	78	0	35	34	35
2025	11	18	16	12	15	25.3	-1	1.11	0.4	0.3	0	35.3	18.9	0	117	77	0	35	33	35
2025	11	18	16	22	15	24.6	-1.2	1.11	0.3	0.2	0	35.3	18.9	0	117	78	0	35	34	35
2025	11	18	16	32	15	24.6	-1.3	1.11	0.3	0.2	0	34.8	18.9	0	116	77	0	35	33	35
2025	11	18	16	42	15	24.5	-1.8	1.11	0.3	0.2	0	34.8	18.9	0	116	78	0	35	34	34
2025	11	18	16	52	15	24	-1	1.11	0.5	0.4	0	34.4	18.1	0	115	76	0	35	34	35
2025	11	18	17	2	15	23.9	-1.6	1.11	0.3	0.2	0	34.4	18.5	0	115	77	0	35	34	35
2025	11	18	17	12	15	22.8	-0.9	1.11	0.4	0.3	0	34.4	18.1	0	115	76	0	35	34	35
2025	11	18	17	22	15	24.6	-1.6	1.11	0.4	0.3	0	34.8	18.5	0	116	77	0	35	34	34
2025	11	18	17	32	15	24.9	-1.2	1.11	0.4	0.3	0	34.8	17.6	0	115	75	0	34	34	34
2025	11	18	17	42	15	24.8	-2	1.11	0.3	0.2	0	34	18.1	0	114	76	0	35	34	35
2025	11	18	17	52	15	24.4	-0.6	1.11	0.3	0.2	0	34	17.6	0	114	75	0	35	34	35
2025	11	18	18	2	15	24.4	-1.2	1.11	0.5	0.4	0	34.4	17.2	0	115	74	0	35	34	35
2025	11	18	18	12	15	23.6	-0.8	1.11	0.3	0.2	0	34.8	18.1	0	116	76	0	35	34	35
2025	11	18	18	22	15	24.9	-2.3	1.11	0.4	0.3	0	34.8	17.6	0	116	75	0	35	34	35
2025	11	18	18	32	15	24.7	-2.7	1.11	0.4	0.3	0	35.3	18.9	0	117	77	0	35	33	35
2025	11	18	18	42	15	24.4	-2.9	1.11	0.4	0.3	0	34.8	18.1	0	116	76	0	35	34	34
2025	11	18	18	52	15	24.9	-2.8	1.11	0.5	0.5	0	35.3	18.1	0	117	76	0	35	34	35
2025	11	18	19	2	15	24.9	-2.3	1.11	0.3	0.2	0	35.3	18.9	0	117	77	0	35	33	35
2025	11	18	19	12	15	24	-3.1	1.11	0.3	0.2	0	35.3	17.6	0	116	75	0	34	34	35
2025	11	18	19	22	15	24.1	-2.5	1.11	0.3	0.2	0	35.3	18.1	0	117	76	0	35	34	34
2025	11	18	19	32	15	23.5	-2	1.11	0.3	0.2	0	34.8	18.1	0	116	76	0	35	34	35
2025	11	18	19	42	15	24.2	-1.7	1.11	0.3	0.2	0	34.4	18.5	0	116	76	0	36	33	34
2025	11	18	19	52	15	23.8	-2	1.11	0.4	0.3	0	35.3	17.6	0	116	75	0	34	34	34
2025	11	18	20	2	15	25.1	-1.8	1.11	0.3	0.2	0	34.8	18.9	0	116	77	0	35	33	34
2025	11	18	20	12	15	25.3	-2.2	1.11	0.4	0.3	0	35.3	17.6	0	117	75	0	35	34	35
2025	11	18	20	22	15	25.3	-2	1.11	0.5	0.4	0	34.8	17.6	0	116	75	0	35	34	34
2025	11	18	20	32	15	26.1	-1.5	1.109	0.4	0.3	0	34.8	18.1	0	116	76	0	35	34	34
2025	11	18	20	42	15	25.7	-1.6	1.109	0.3	0.2	0	35.3	18.1	0	117	76	0	35	34	35
2025	11	18	20	52	15	23.6	-1.4	1.109	0.3	0.2	0	34.8	17.6	0	115	75	0	34	34	35
2025	11	18	21	2	15	24.1	-1	1.109	0.3	0.2	0	34.8	18.1	0	116	76	0	35	34	34
2025	11	18	21	12	15	24.6	-1	1.109	0.5	0.5	0	34.8	18.1	0	116	76	0	35	34	35
2025	11	18	21	22	15	24.2	-1.6	1.109	0.3	0.2	0	34.8	18.1	0	116	76	0	35	34	35
2025	11	18	21	32	15	24.8	-0.4	1.109	0.3	0.2	0	35.3	18.5	0	117	77	0	35	34	36
2025	11	18	21	42	15	23.7	-1.1	1.109	0.3	0.2	0	35.3	18.1	0	117	76	0	35	34	35
2025	11	18	21	52	15	25.6	-1.5	1.109	0.3	0.2	0	34.8	18.5	0	117	76	0	36	33	35
2025	11	18	22	2	15	24.2	-1.9	1.108	0.3	0.2	0	35.3	18.9	0	117	77	0	35	33	35
2025	11	18	22	12	15	25	-1.7	1.108	0.4	0.3	0	35.3	18.5	0	117	77	0	35	34	35
2025	11	18	22	22	15	24.3	-0.8	1.108	0.3	0.2	0	34.8	18.5	0	116	77	0	35	34	35
2025	11	18	22	32	15	24.1	-0.4	1.108	0.5	0.5	0	35.7	18.5	0	117	77	0	34	34	35
2025	11	18	22	42	15	24.8	-0.4	1.108	0.3	0.2	0	35.3	18.9	0	117	77	0	35	33	35
2025	11	18	22	52	15	23.8	-2.1	1.108	0.3	0.2	0	35.3	18.5	0	117	76	0	35	33	35
2025	11	18	23	2	15	22.3	-0.7	1.108	0.4	0.3	0	35.3	18.1	0	117	76	0	35	34	35
2025	11	18	23	12	15	24.6	-2.9	1.108	0.3	0.2	0	35.7	18.1	0	117	76	0	34	34	34
2025	11	18	23	22	15	24.6	-1.6	1.108	0.4	0.3	0	35.3	18.9	0	117	77	0	35	33	35
2025	11	18	23	32	15	23.8	-2.3	1.108	0.3	0.2	0	35.7	18.5	0	118	77	0	35	34	35
2025	11	18	23	42	15	23.3	-1.5	1.107	0.3	0.2	0	35.3	18.1	0	117	77	0	35	35	34
2025	11	18	23	52	15	24.7	-2.2	1.107	0.3	0.2	0	35.3	18.9	0	117	77	0	35	33	34

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	19	0	2	15	24.4	-2	1.107	0.3	0.2	0	35.7	18.5	0	117	77	0	34	34	35
2025	11	19	0	12	15	24	-0.9	1.107	0.4	0.3	0	35.3	18.1	0	117	76	0	35	34	35
2025	11	19	0	22	15	24.6	-2.9	1.107	0.5	0.4	0	35.3	18.5	0	117	76	0	35	33	35
2025	11	19	0	32	15	25.7	-2.3	1.107	0.4	0.3	0	35.7	18.5	0	117	76	0	34	33	35
2025	11	19	0	42	15	23.5	-1.9	1.107	0.4	0.3	0	35.3	18.1	0	117	76	0	35	34	35
2025	11	19	0	52	15	24.9	-2.5	1.107	0.4	0.3	0	35.7	18.5	0	118	77	0	35	34	35
2025	11	19	1	2	15	24.3	-1.8	1.106	0.4	0.3	0	37	19.4	0	121	79	0	35	34	35
2025	11	19	1	12	15	25.7	-2	1.107	0.4	0.3	0	36.1	18.9	0	119	78	0	35	34	35
2025	11	19	1	22	15	24.4	-2	1.106	0.3	0.2	0	37	19.8	0	121	80	0	35	34	34
2025	11	19	1	32	15	25.3	-2.1	1.106	0.3	0.2	0	35.7	19.4	0	118	78	0	35	33	35
2025	11	19	1	42	15	24.2	-1.6	1.106	0.3	0.2	0	35.7	18.5	0	118	77	0	35	34	34
2025	11	19	1	52	15	25.1	-2.5	1.106	0.3	0.2	0	35.7	18.5	0	118	77	0	35	34	35
2025	11	19	2	2	15	25.6	-2.2	1.106	0.3	0.2	0	35.3	18.5	0	117	77	0	35	34	35
2025	11	19	2	12	15	25.5	-2.4	1.105	0.5	0.4	0	35.3	18.1	0	117	76	0	35	34	35
2025	11	19	2	22	15	25.1	-1.6	1.105	0.5	0.5	0	35.3	18.5	0	117	77	0	35	34	35
2025	11	19	2	32	15	23.4	-1.7	1.105	0.4	0.3	0	35.3	18.1	0	117	77	0	35	35	35
2025	11	19	2	42	15	24.3	-2	1.105	0.3	0.2	0	35.3	18.9	0	117	77	0	35	33	34
2025	11	19	2	52	15	24	-1.9	1.105	0.5	0.5	0	35.3	18.5	0	117	77	0	35	34	35
2025	11	19	3	2	15	23.8	-1.8	1.105	0.4	0.3	0	34.4	18.1	0	116	77	0	36	35	35
2025	11	19	3	12	15	23.8	-1.8	1.105	0.4	0.3	0	34.8	18.5	0	116	77	0	35	34	35
2025	11	19	3	22	15	24.6	-1.6	1.105	0.3	0.2	0	34.8	18.1	0	117	76	0	36	34	34
2025	11	19	3	32	15	24.8	-0.9	1.105	0.5	0.4	0	35.7	18.1	0	118	76	0	35	34	34
2025	11	19	3	42	15	25.6	-2	1.105	0.3	0.2	0	35.3	18.1	0	117	76	0	35	34	35
2025	11	19	3	52	15	24.3	-1.9	1.105	0.3	0.2	0	35.3	18.5	0	117	77	0	35	34	35
2025	11	19	4	2	15	24.7	-1.4	1.105	0.5	0.4	0	35.3	18.5	0	117	76	0	35	33	35
2025	11	19	4	12	15	25.1	-2.1	1.105	0.5	0.4	0	34.8	18.1	0	117	76	0	36	34	35
2025	11	19	4	22	15	24.1	-1.8	1.105	0.4	0.3	0	35.3	18.1	0	117	76	0	35	34	34
2025	11	19	4	32	15	25.1	-1.7	1.104	0.3	0.2	0	35.3	17.6	0	117	75	0	35	34	35
2025	11	19	4	42	15	25.9	-1.5	1.104	0.4	0.3	0	35.3	18.1	0	117	76	0	35	34	35
2025	11	19	4	52	15	25.9	-2	1.104	0.3	0.2	0	35.7	18.5	0	117	76	0	34	33	35
2025	11	19	5	2	15	24.4	-0.8	1.104	0.3	0.2	0	35.3	18.5	0	117	77	0	35	34	36
2025	11	19	5	12	15	24.2	-2.1	1.104	0.3	0.2	0	35.3	18.1	0	117	76	0	35	34	35
2025	11	19	5	22	15	24.3	-2	1.104	0.5	0.4	0	35.3	18.1	0	117	76	0	35	34	35
2025	11	19	5	32	15	25.2	-1.3	1.103	0.3	0.2	0	34.8	18.1	0	117	76	0	36	34	35
2025	11	19	5	42	15	25.1	-2.3	1.103	0.5	0.4	0	35.3	18.1	0	117	76	0	35	34	34
2025	11	19	5	52	15	24	-1.7	1.103	0.3	0.2	0	35.3	18.1	0	117	76	0	35	34	34
2025	11	19	6	2	15	24.3	-1.9	1.103	0.5	0.5	0	34.8	18.1	0	117	76	0	36	34	35
2025	11	19	6	12	15	25	-1.6	1.103	0.4	0.3	0	35.3	18.1	0	117	76	0	35	34	35
2025	11	19	6	22	15	24	-1.6	1.103	0.5	0.4	0	35.3	18.1	0	117	76	0	35	34	35
2025	11	19	6	32	15	24.5	0	1.103	0.5	0.4	0	35.3	18.5	0	117	77	0	35	34	35
2025	11	19	6	42	15	24.9	-1.3	1.102	0.4	0.3	0	35.3	18.5	0	117	77	0	35	34	35
2025	11	19	6	52	15	25.2	-2.1	1.102	0.4	0.3	0	35.7	18.5	0	118	77	0	35	34	35
2025	11	19	7	2	15	25.6	-2	1.102	0.4	0.3	0	36.1	18.9	0	119	78	0	35	34	35
2025	11	19	7	12	15	24.5	-1.2	1.102	0.3	0.2	0	37	19.4	0	121	79	0	35	34	34
2025	11	19	7	22	15	25.5	-1.6	1.102	0.3	0.2	0	37	19.4	0	121	79	0	35	34	35
2025	11	19	7	32	15	24.5	-1.6	1.102	0.3	0.2	0	36.5	19.4	0	120	79	0	35	34	35
2025	11	19	7	42	15	25.6	-1.6	1.102	0.3	0.2	0	36.5	19.4	0	120	79	0	35	34	34
2025	11	19	7	52	15	25.1	-2.3	1.102	0.4	0.3	0	36.1	20.2	0	119	81	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	19	8	2	15	24.4	-1.2	1.102	0.3	0.2	0	36.1	19.8	0	119	80	0	35	34	34
2025	11	19	8	12	15	25.4	-1.3	1.102	0.5	0.4	0	35.7	18.9	0	118	78	0	35	34	34
2025	11	19	8	22	15	25.4	-2.1	1.102	0.3	0.2	0	35.7	18.5	0	118	77	0	35	34	35
2025	11	19	8	32	15	25	-1.1	1.102	0.3	0.2	0	35.3	18.5	0	117	76	0	35	33	35
2025	11	19	8	42	15	25	-1.7	1.102	0.5	0.5	0	34.4	18.1	0	116	76	0	36	34	34
2025	11	19	8	52	15	25.2	-2.1	1.101	0.3	0.2	0	34.8	18.1	0	116	76	0	35	34	35
2025	11	19	9	2	15	25.6	-1.4	1.101	0.5	0.4	0	34.8	17.6	0	116	75	0	35	34	35
2025	11	19	9	12	15	25	-1.1	1.1	0.4	0.3	0	34.4	18.1	0	116	76	0	36	34	34
2025	11	19	9	22	15	24.4	-1.8	1.1	0.4	0.3	0	34.4	17.6	0	115	75	0	35	34	35
2025	11	19	9	32	15	25.5	-1.1	1.1	0.3	0.2	0	34.4	18.1	0	115	75	0	35	33	35
2025	11	19	9	42	15	25.6	-1.6	1.1	0.4	0.3	0	34.4	17.6	0	115	75	0	35	34	35
2025	11	19	9	52	15	25.6	-1.6	1.099	0.4	0.3	0	34.4	18.1	0	115	76	0	35	34	35
2025	11	19	10	2	15	24.9	-2	1.099	0.3	0.2	0	34.4	18.1	0	115	76	0	35	34	35
2025	11	19	10	12	15	24.9	-1.6	1.099	0.3	0.2	0	34.4	18.1	0	115	76	0	35	34	35
2025	11	19	10	22	15	26	-1.2	1.098	0.4	0.3	0	34.4	17.6	0	115	75	0	35	34	35
2025	11	19	10	32	15	24.6	-1.8	1.098	0.4	0.3	0	34	18.5	0	114	76	0	35	33	35
2025	11	19	10	42	15	25.7	-2.3	1.098	0.5	0.4	0	34.4	17.6	0	115	75	0	35	34	35
2025	11	19	10	52	15	25.1	-0.8	1.098	0.4	0.3	0	34.4	17.6	0	115	75	0	35	34	35
2025	11	19	11	2	15	25.7	-2.3	1.097	0.3	0.2	0	34.4	18.1	0	115	76	0	35	34	35
2025	11	19	11	12	15	24.8	-1.9	1.097	0.3	0.2	0	34.4	17.6	0	114	75	0	34	34	35
2025	11	19	11	22	15	24.7	-1.2	1.097	0.3	0.2	0	34	17.6	0	114	75	0	35	34	35
2025	11	19	11	32	15	25.2	-1.7	1.097	0.4	0.3	0	33.5	18.1	0	114	76	0	36	34	35
2025	11	19	11	42	15	25.9	-1.6	1.097	0.3	0.2	0	34	17.6	0	114	75	0	35	34	35
2025	11	19	11	52	15	25	-1.6	1.097	0.4	0.3	0	34	17.6	0	114	75	0	35	34	35
2025	11	19	12	2	15	24.8	-1.2	1.097	0.3	0.2	0	34.8	18.5	0	116	78	0	35	35	34
2025	11	19	12	12	15	25.2	-1.9	1.097	0.5	0.4	0	34.8	18.9	0	116	78	0	35	34	35
2025	11	19	12	22	15	24.5	-0.6	1.097	0.4	0.3	0	34.8	18.9	0	116	77	0	35	33	35
2025	11	19	12	32	15	25.6	-1.6	1.097	0.5	0.4	0	34.4	18.9	0	115	77	0	35	33	35
2025	11	19	12	42	15	25.3	-1.6	1.097	0.3	0.2	0	33.5	18.1	0	113	75	0	35	33	35
2025	11	19	12	52	15	25.1	-1.5	1.097	0.3	0.2	0	33.5	17.6	0	113	75	0	35	34	35
2025	11	19	13	2	15	24.7	-1.6	1.096	0.3	0.2	0	34.4	18.1	0	114	75	0	34	33	34
2025	11	19	13	12	15	24.7	-1.9	1.096	0.3	0.2	0	34	18.1	0	114	76	0	35	34	35
2025	11	19	13	22	15	25.1	-1.5	1.097	0.4	0.3	0	34.4	18.5	0	115	77	0	35	34	35
2025	11	19	13	32	15	25	-1.6	1.097	0.5	0.4	0	34.4	18.9	0	115	77	0	35	33	35
2025	11	19	13	42	15	24.5	-1.6	1.096	0.5	0.5	0	34.4	18.9	0	115	78	0	35	34	35
2025	11	19	13	52	15	23.1	-1.6	1.096	0.3	0.2	0	34.8	18.5	0	116	77	0	35	34	35
2025	11	19	14	2	15	24	-0.4	1.096	0.4	0.3	0	34.4	18.9	0	116	78	0	36	34	35
2025	11	19	14	12	15	24	-0.4	1.096	0.3	0.2	0	34.4	18.5	0	115	77	0	35	34	35
2025	11	19	14	22	15	24.5	-2.5	1.096	0.5	0.4	0	34.4	18.5	0	115	77	0	35	34	35
2025	11	19	14	32	15	25.4	-2.1	1.096	0.4	0.3	0	34	17.6	0	114	75	0	35	34	35
2025	11	19	14	42	15	24.7	-1.1	1.096	0.3	0.2	0	34	18.1	0	114	76	0	35	34	35
2025	11	19	14	52	15	25.1	-0.7	1.096	0.3	0.2	0	34	17.6	0	114	75	0	35	34	35
2025	11	19	15	2	15	24.8	-1.6	1.095	0.4	0.3	0	34.4	18.5	0	115	77	0	35	34	35
2025	11	19	15	12	15	24.3	-1	1.095	0.5	0.4	0	34.8	19.4	0	115	78	0	34	33	34
2025	11	19	15	22	15	24.8	-1.8	1.095	0.3	0.2	0	34.8	18.5	0	116	77	0	35	34	35
2025	11	19	15	32	15	23.6	-1	1.095	0.3	0.2	0	34	17.6	0	114	75	0	35	34	35
2025	11	19	15	42	15	24.2	-1.6	1.095	0.3	0.2	0	34	17.6	0	114	75	0	35	34	35
2025	11	19	15	52	15	24.9	-1.6	1.095	0.3	0.2	0	33.5	17.6	0	113	74	0	35	33	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	19	16	2	15	24.6	-1.3	1.094	0.4	0.3	0	34	17.6	0	114	75	0	35	34	35
2025	11	19	16	12	15	24.6	-2	1.094	0.4	0.3	0	33.5	17.2	0	113	74	0	35	34	35
2025	11	19	16	22	15	24	-2.1	1.094	0.4	0.3	0	33.5	18.1	0	113	75	0	35	33	35
2025	11	19	16	32	15	24.4	-2.4	1.094	0.5	0.4	0	33.5	17.2	0	113	74	0	35	34	34
2025	11	19	16	42	15	25.3	-0.9	1.094	0.4	0.3	0	34	17.6	0	114	75	0	35	34	34
2025	11	19	16	52	15	24	-1.8	1.093	0.3	0.2	0	33.5	18.1	0	113	76	0	35	34	35
2025	11	19	17	2	15	23.3	-2.3	1.093	0.3	0.2	0	33.5	17.6	0	114	75	0	36	34	35
2025	11	19	17	12	15	23.6	-1.5	1.093	0.5	0.4	0	34.4	17.6	0	115	75	0	35	34	34
2025	11	19	17	22	15	25.3	-2	1.093	0.3	0.2	0	34.8	17.6	0	115	75	0	34	34	35
2025	11	19	17	32	15	24.2	-1.7	1.093	0.4	0.3	0	34	17.6	0	114	75	0	35	34	34
2025	11	19	17	42	15	25.1	-2.1	1.093	0.3	0.2	0	34	17.6	0	114	75	0	35	34	35
2025	11	19	17	52	15	24.4	-2.1	1.092	0.4	0.3	0	34	17.2	0	114	74	0	35	34	35
2025	11	19	18	2	15	25.8	-2.5	1.092	0.3	0.2	0	34	17.6	0	114	75	0	35	34	35
2025	11	19	18	12	15	24.8	-2	1.092	0.4	0.3	0	34.4	18.5	0	115	76	0	35	33	35
2025	11	19	18	22	15	24.5	-2.1	1.092	0.4	0.3	0	34.4	17.6	0	115	75	0	35	34	34
2025	11	19	18	32	15	25.5	-2.1	1.092	0.3	0.2	0	34.8	18.1	0	116	76	0	35	34	35
2025	11	19	18	42	15	25.4	-1.3	1.092	0.3	0.2	0	34.4	18.1	0	115	76	0	35	34	35
2025	11	19	18	52	15	24.6	-2.1	1.092	0.4	0.3	0	34.8	18.1	0	116	76	0	35	34	35
2025	11	19	19	2	15	23.8	-1.8	1.091	0.4	0.3	0	34.4	17.6	0	115	76	0	35	35	35
2025	11	19	19	12	15	24.3	-1.6	1.091	0.4	0.3	0	34.8	18.5	0	115	76	0	34	33	35
2025	11	19	19	22	15	24.4	-2.6	1.09	0.3	0.2	0	34.8	18.9	0	116	78	0	35	34	35
2025	11	19	19	32	15	23.1	-1.3	1.089	0.5	0.4	0	34.4	18.5	0	115	77	0	35	34	35
2025	11	19	19	42	15	23.9	-2.2	1.089	0.4	0.3	0	34.8	18.5	0	116	77	0	35	34	35
2025	11	19	19	52	15	24.8	-1.3	1.09	0.3	0.2	0	34.8	18.5	0	116	77	0	35	34	34
2025	11	19	20	2	15	25.7	-1.9	1.089	0.4	0.3	0	34.4	18.5	0	115	77	0	35	34	34
2025	11	19	20	12	15	24.3	-2.1	1.088	0.3	0.2	0	34.8	18.5	0	115	77	0	34	34	35
2025	11	19	20	22	15	24.6	-1.6	1.088	0.3	0.2	0	34.8	18.5	0	116	77	0	35	34	34
2025	11	19	20	32	15	24.8	-1.6	1.088	0.4	0.3	0	34.8	18.1	0	116	76	0	35	34	35
2025	11	19	20	42	15	25.3	-1.2	1.087	0.4	0.3	0	34.4	18.5	0	115	76	0	35	33	34
2025	11	19	20	52	15	24	-1.6	1.086	0.3	0.2	0	34.4	18.5	0	115	77	0	35	34	35
2025	11	19	21	2	15	24	-2.2	1.086	0.5	0.4	0	34.4	18.1	0	115	76	0	35	34	35
2025	11	19	21	12	15	24.3	-2.3	1.086	0.4	0.3	0	34.4	18.1	0	115	76	0	35	34	35
2025	11	19	21	22	15	24.6	-2.6	1.086	0.4	0.3	0	34.4	18.1	0	115	76	0	35	34	34
2025	11	19	21	32	15	25	-2.5	1.086	0.4	0.3	0	34.4	18.5	0	115	77	0	35	34	34
2025	11	19	21	42	15	23.9	-1.3	1.086	0.4	0.3	0	34.8	18.5	0	116	77	0	35	34	35
2025	11	19	21	52	15	24.4	-1.7	1.085	0.3	0.2	0	34.8	18.5	0	116	77	0	35	34	35
2025	11	19	22	2	15	24.4	-1.1	1.085	0.5	0.4	0	34.8	18.5	0	116	77	0	35	34	35
2025	11	19	22	12	15	25.7	-1.8	1.085	0.3	0.2	0	34.8	18.5	0	116	77	0	35	34	35
2025	11	19	22	22	15	24.5	-2.2	1.085	0.5	0.4	0	35.3	18.1	0	116	77	0	34	35	35
2025	11	19	22	32	15	24	-1.6	1.085	0.4	0.3	0	34.8	18.9	0	116	78	0	35	34	35
2025	11	19	22	42	15	24.4	-1.3	1.085	0.3	0.2	0	34.8	19.4	0	116	78	0	35	33	35
2025	11	19	22	52	15	24.2	-2.2	1.085	0.4	0.3	0	35.3	18.9	0	116	78	0	34	34	35
2025	11	19	23	2	15	23.9	-1.6	1.085	0.3	0.2	0	34.8	18.9	0	116	78	0	35	34	34
2025	11	19	23	12	15	24.7	-1.2	1.084	0.5	0.4	0	35.3	18.9	0	117	78	0	35	34	34
2025	11	19	23	22	15	24	-1.9	1.084	0.4	0.3	0	34.8	18.9	0	117	78	0	36	34	35
2025	11	19	23	32	15	24.1	-1	1.084	0.3	0.2	0	35.7	18.9	0	117	78	0	34	34	34
2025	11	19	23	42	15	25.1	-1.5	1.084	0.5	0.5	0	34.8	18.9	0	116	78	0	35	34	35
2025	11	19	23	52	15	23.9	-1.7	1.084	0.3	0.2	0	35.3	19.4	0	117	79	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	20	0	2	15	23.5	-0.5	1.084	0.3	0.2	0	35.7	19.4	0	118	79	0	35	34	35
2025	11	20	0	12	15	24	-1.6	1.084	0.4	0.3	0	35.3	18.9	0	117	78	0	35	34	34
2025	11	20	0	22	15	24.6	-1.2	1.083	0.3	0.2	0	35.3	18.9	0	117	78	0	35	34	34
2025	11	20	0	32	15	24.1	-1.8	1.083	0.4	0.3	0	35.7	19.4	0	118	79	0	35	34	35
2025	11	20	0	42	15	23.5	-1.7	1.083	0.4	0.3	0	35.3	19.4	0	117	79	0	35	34	35
2025	11	20	0	52	15	23.5	-0.4	1.083	0.4	0.3	0	35.3	18.9	0	117	78	0	35	34	35
2025	11	20	1	2	15	24.4	-1.8	1.083	0.4	0.3	0	35.3	19.4	0	117	79	0	35	34	35
2025	11	20	1	12	15	24.1	-1.3	1.083	0.3	0.2	0	34.8	18.9	0	116	78	0	35	34	35
2025	11	20	1	22	15	24.5	-1.4	1.082	0.3	0.2	0	34.8	18.5	0	116	77	0	35	34	35
2025	11	20	1	32	15	23.8	-0.8	1.083	0.4	0.3	0	35.3	19.4	0	117	80	0	35	35	34
2025	11	20	1	42	15	23.5	-1.3	1.083	0.5	0.4	0	35.3	19.4	0	117	79	0	35	34	34
2025	11	20	1	52	15	24.4	-2	1.083	0.3	0.2	0	35.3	19.8	0	117	79	0	35	33	34
2025	11	20	2	2	15	24.7	-1.1	1.082	0.4	0.3	0	35.3	19.8	0	117	79	0	35	33	34
2025	11	20	2	12	15	24.2	-0.6	1.082	0.3	0.2	0	35.3	18.9	0	117	79	0	35	35	35
2025	11	20	2	22	15	24	-1.4	1.082	0.4	0.3	0	35.3	19.8	0	117	80	0	35	34	35
2025	11	20	2	32	15	24	-1.7	1.082	0.3	0.2	0	35.3	19.4	0	117	79	0	35	34	35
2025	11	20	2	42	15	23.9	-2	1.082	0.3	0.2	0	35.7	20.2	0	118	81	0	35	34	35
2025	11	20	2	52	15	23.9	-1.8	1.082	0.3	0.2	0	35.3	19.4	0	117	79	0	35	34	34
2025	11	20	3	2	15	23.5	-0.9	1.082	0.4	0.3	0	35.3	20.2	0	117	81	0	35	34	35
2025	11	20	3	12	15	23.8	-2.3	1.082	0.5	0.4	0	35.3	19.8	0	117	80	0	35	34	35
2025	11	20	3	22	15	24.1	-0.7	1.082	0.3	0.2	0	35.3	20.2	0	117	81	0	35	34	35
2025	11	20	3	32	15	24.4	-1.2	1.082	0.4	0.3	0	35.3	19.8	0	117	80	0	35	34	35
2025	11	20	3	42	15	24.3	-0.7	1.082	0.4	0.3	0	38.3	22.4	0	124	86	0	35	34	35
2025	11	20	3	52	15	23	-1.7	1.082	0.4	0.3	0	36.1	20.2	0	119	81	0	35	34	35
2025	11	20	4	2	15	24.1	-2.1	1.082	0.4	0.3	0	35.3	19.8	0	118	80	0	36	34	35
2025	11	20	4	12	15	24.3	-2.5	1.082	0.5	0.4	0	36.1	19.8	0	119	80	0	35	34	35
2025	11	20	4	22	15	23.8	-2.1	1.082	0.5	0.5	0	37.8	21.9	0	123	86	0	35	35	35
2025	11	20	4	32	15	24.3	-2.2	1.082	0.5	0.4	0	38.7	22.4	0	125	86	0	35	34	35
2025	11	20	4	42	15	23.5	-1.9	1.082	0.3	0.2	0	36.1	20.6	0	119	82	0	35	34	35
2025	11	20	4	52	15	24	-2.1	1.081	0.5	0.4	0	35.7	19.8	0	118	80	0	35	34	34
2025	11	20	5	2	15	23.3	-2.6	1.081	0.3	0.2	0	37.4	21.5	0	122	84	0	35	34	35
2025	11	20	5	12	15	24.7	-1.9	1.081	0.3	0.2	0	36.5	20.6	0	120	82	0	35	34	34
2025	11	20	5	22	15	24.3	-1.8	1.081	0.4	0.3	0	36.1	20.2	0	119	81	0	35	34	34
2025	11	20	5	32	15	24.3	-2.5	1.081	0.3	0.2	0	35.7	20.2	0	118	81	0	35	34	35
2025	11	20	5	42	15	23.7	-1.7	1.081	0.3	0.2	0	35.7	20.2	0	118	81	0	35	34	35
2025	11	20	5	52	15	23.2	-2.4	1.081	0.4	0.3	0	35.7	20.2	0	118	80	0	35	33	35
2025	11	20	6	2	15	24	-1.6	1.081	0.4	0.3	0	35.7	19.8	0	118	80	0	35	34	36
2025	11	20	6	12	15	24.8	-1.7	1.081	0.3	0.2	0	35.7	20.6	0	118	81	0	35	33	35
2025	11	20	6	22	15	23.8	-1.8	1.081	0.3	0.2	0	35.3	20.2	0	117	80	0	35	33	34
2025	11	20	6	32	15	24.4	-1.8	1.081	0.4	0.3	0	35.7	20.2	0	117	81	0	34	34	35
2025	11	20	6	42	15	24.3	-1.5	1.081	0.5	0.4	0	35.3	19.8	0	117	80	0	35	34	34
2025	11	20	6	52	15	24.1	-3.3	1.081	0.3	0.2	0	35.7	19.8	0	118	80	0	35	34	35
2025	11	20	7	2	15	23.9	-1.5	1.081	0.3	0.2	0	35.7	20.2	0	118	81	0	35	34	34
2025	11	20	7	12	15	24.3	-2.1	1.081	0.3	0.2	0	35.3	19.4	0	117	80	0	35	35	35
2025	11	20	7	22	15	23.9	-3.1	1.081	0.3	0.2	0	35.7	20.2	0	118	81	0	35	34	35
2025	11	20	7	32	15	23.9	-2.5	1.081	0.4	0.3	0	35.7	19.8	0	118	80	0	35	34	35
2025	11	20	7	42	15	23.9	-2.3	1.081	0.5	0.4	0	35.3	19.8	0	117	80	0	35	34	35
2025	11	20	7	52	15	24.4	-2.1	1.081	0.3	0.2	0	35.3	19.8	0	117	80	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	20	8	2	15	25.5	-3.3	1.081	0.3	0.2	0	35.3	19.4	0	117	79	0	35	34	34
2025	11	20	8	12	15	24	-2.4	1.08	0.4	0.3	0	35.3	19.8	0	117	80	0	35	34	35
2025	11	20	8	22	15	24.1	-1.6	1.081	0.5	0.4	0	34.8	19.8	0	116	81	0	35	35	34
2025	11	20	8	32	15	24.9	-2.3	1.081	0.3	0.2	0	35.3	19.4	0	116	79	0	34	34	34
2025	11	20	8	42	15	24.6	-3.1	1.081	0.5	0.4	0	34.8	20.2	0	116	81	0	35	34	34
2025	11	20	8	52	15	24.7	-2.4	1.081	0.3	0.2	0	34.8	19.8	0	116	80	0	35	34	34
2025	11	20	9	2	15	23.2	-2.4	1.081	0.4	0.3	0	34.8	19.4	0	116	79	0	35	34	35
2025	11	20	9	12	15	23.6	-1.8	1.081	0.3	0.2	0	34.4	19.4	0	115	79	0	35	34	35
2025	11	20	9	22	15	25.1	-3.7	1.081	0.3	0.2	0	34	18.9	0	114	78	0	35	34	35
2025	11	20	9	32	15	23.9	-1.2	1.081	0.4	0.3	0	33.5	18.9	0	114	78	0	36	34	35
2025	11	20	9	42	15	24.8	-3	1.081	0.5	0.5	0	34	18.5	0	114	77	0	35	34	34
2025	11	20	9	52	15	23	-2.5	1.081	0.3	0.2	0	33.5	18.5	0	114	77	0	36	34	35
2025	11	20	10	2	15	25	-1.6	1.081	0.3	0.2	0	34	18.5	0	114	77	0	35	34	35
2025	11	20	10	12	15	24.7	-3.3	1.081	0.4	0.3	0	33.5	18.1	0	113	76	0	35	34	34
2025	11	20	10	22	15	23.9	-2	1.081	0.5	0.4	0	34	18.5	0	114	77	0	35	34	34
2025	11	20	10	32	15	25.2	-2.9	1.081	0.3	0.2	0	34	18.1	0	113	76	0	34	34	35
2025	11	20	10	42	15	22.7	-2	1.081	0.3	0.2	0	33.5	18.5	0	113	77	0	35	34	35
2025	11	20	10	52	15	23	-3	1.081	0.4	0.3	0	33.5	18.1	0	113	76	0	35	34	35
2025	11	20	11	2	15	25.2	-2.1	1.082	0.5	0.5	0	33.5	18.1	0	113	76	0	35	34	34
2025	11	20	11	12	15	24.7	-2.5	1.082	0.4	0.3	0	33.5	18.1	0	113	76	0	35	34	35
2025	11	20	11	22	15	23.1	-3.1	1.082	0.5	0.4	0	34	18.5	0	114	77	0	35	34	35
2025	11	20	11	32	15	24.4	-2.4	1.082	0.5	0.4	0	34	18.1	0	114	76	0	35	34	35
2025	11	20	11	42	15	24.5	-3	1.082	0.4	0.3	0	34.4	18.5	0	115	77	0	35	34	34
2025	11	20	11	52	15	23.8	-3.4	1.082	0.3	0.2	0	34	18.5	0	114	77	0	35	34	34
2025	11	20	12	2	15	23.4	-1.7	1.082	0.4	0.3	0	33.5	18.1	0	113	77	0	35	35	34
2025	11	20	12	12	15	23.7	-2.2	1.082	0.4	0.3	0	34	18.5	0	114	77	0	35	34	35
2025	11	20	12	22	15	23.9	-2	1.082	0.4	0.3	0	33.5	18.5	0	113	77	0	35	34	35
2025	11	20	12	32	15	24.3	-2.1	1.082	0.3	0.2	0	33.5	18.5	0	113	77	0	35	34	34
2025	11	20	12	42	15	24.5	-2.1	1.082	0.4	0.3	0	33.5	18.1	0	113	76	0	35	34	35
2025	11	20	12	52	15	25.6	-2.8	1.082	0.4	0.3	0	34	18.5	0	114	77	0	35	34	35
2025	11	20	13	2	15	24.1	-2.6	1.082	0.4	0.3	0	34	18.5	0	114	77	0	35	34	35
2025	11	20	13	12	15	24.4	-0.6	1.082	0.5	0.5	0	34	18.9	0	114	77	0	35	33	34
2025	11	20	13	22	15	25.1	-2.6	1.082	0.5	0.5	0	34	18.9	0	114	78	0	35	34	35
2025	11	20	13	32	15	24.5	-3	1.082	0.3	0.2	0	33.5	18.5	0	114	77	0	36	34	35
2025	11	20	13	42	15	23.9	-1.3	1.083	0.4	0.3	0	33.5	18.5	0	113	77	0	35	34	34
2025	11	20	13	52	15	24.2	-1.6	1.083	0.5	0.4	0	33.1	18.1	0	113	76	0	36	34	35
2025	11	20	14	2	15	24.2	-0.6	1.083	0.3	0.2	0	33.1	18.1	0	113	76	0	36	34	35
2025	11	20	14	12	15	24.7	-1.7	1.083	0.4	0.3	0	33.5	18.1	0	113	76	0	35	34	35
2025	11	20	14	22	15	25.2	-2.2	1.083	0.3	0.2	0	33.5	18.5	0	113	77	0	35	34	35
2025	11	20	14	32	15	24.8	-2.9	1.083	0.3	0.2	0	33.5	18.5	0	113	77	0	35	34	35
2025	11	20	14	42	15	23.3	-1.5	1.083	0.4	0.3	0	33.5	18.9	0	113	77	0	35	33	35
2025	11	20	14	52	15	24.2	-1.7	1.083	0.4	0.3	0	34	18.5	0	114	77	0	35	34	35
2025	11	20	15	2	15	23	-1.5	1.083	0.4	0.3	0	33.5	17.6	0	113	76	0	35	35	35
2025	11	20	15	12	15	24	-1.6	1.083	0.4	0.3	0	33.5	18.9	0	113	78	0	35	34	35
2025	11	20	15	22	15	24.8	-1.6	1.084	0.3	0.2	0	33.5	18.5	0	113	77	0	35	34	35
2025	11	20	15	32	15	24.1	-1.2	1.083	0.3	0.2	0	34	18.5	0	114	77	0	35	34	35
2025	11	20	15	42	15	25.4	-2.1	1.083	0.4	0.3	0	36.1	20.6	0	119	82	0	35	34	34
2025	11	20	15	52	15	24.3	-1.3	1.084	0.4	0.3	0	34.8	19.4	0	116	79	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	20	16	2	15	24.3	-2.3	1.084	0.4	0.3	0	35.3	20.6	0	117	81	0	35	33	35
2025	11	20	16	12	15	26	-1.1	1.084	0.4	0.3	0	35.7	20.2	0	118	81	0	35	34	35
2025	11	20	16	22	15	24.8	-1.6	1.084	0.3	0.2	0	35.7	20.2	0	118	81	0	35	34	34
2025	11	20	16	32	15	25.5	-2.5	1.084	0.4	0.3	0	37	21.5	0	121	83	0	35	33	35
2025	11	20	16	42	15	24.9	-1.8	1.084	0.3	0.2	0	37.8	22.4	0	123	86	0	35	34	35
2025	11	20	16	52	15	26.4	-1.7	1.085	0.3	0.2	0	38.3	22.4	0	124	86	0	35	34	34
2025	11	20	17	2	15	25.1	-2.5	1.085	0.5	0.4	0	39.1	23.2	0	126	88	0	35	34	34
2025	11	20	17	12	15	25.8	-1.6	1.086	0.5	0.4	0	38.7	22.8	0	126	87	0	36	34	34
2025	11	20	17	22	15	26.5	-2.1	1.086	0.3	0.2	0	39.1	23.2	0	126	88	0	35	34	35
2025	11	20	17	32	15	26.2	-2.1	1.087	0.3	0.2	0	39.1	22.8	0	126	87	0	35	34	35
2025	11	20	17	42	15	27.1	-2.5	1.089	0.3	0.2	0	39.1	23.2	0	126	88	0	35	34	35
2025	11	20	17	52	15	25	-3	1.089	0.3	0.2	0	38.7	23.2	0	125	88	0	35	34	34
2025	11	20	18	2	15	25.3	-2.5	1.09	0.4	0.3	0	39.1	22.8	0	125	87	0	34	34	34
2025	11	20	18	12	15	25.5	-1.2	1.09	0.4	0.3	0	38.7	23.2	0	125	87	0	35	33	34
2025	11	20	18	22	15	25.9	-2.1	1.091	0.4	0.3	0	39.6	23.6	0	127	89	0	35	34	35
2025	11	20	18	32	15	25.1	-2.5	1.091	0.3	0.2	0	40.4	24.1	0	129	90	0	35	34	35
2025	11	20	18	42	15	25.6	-1.2	1.092	0.3	0.2	0	40	24.1	0	128	90	0	35	34	35
2025	11	20	18	52	15	24.5	-1.1	1.092	0.3	0.2	0	40	24.1	0	128	90	0	35	34	35
2025	11	20	19	2	15	25.6	-1.9	1.093	0.3	0.2	0	39.6	23.6	0	127	89	0	35	34	34
2025	11	20	19	12	15	26.4	-1.2	1.093	0.4	0.3	0	39.6	23.6	0	127	89	0	35	34	35
2025	11	20	19	22	15	25.2	-2	1.093	0.3	0.2	0	39.1	23.6	0	126	89	0	35	34	35
2025	11	20	19	32	15	25.1	-2.1	1.093	0.4	0.3	0	39.1	23.6	0	126	88	0	35	33	35
2025	11	20	19	42	15	26.6	-3.2	1.094	0.3	0.2	0	38.3	22.8	0	125	87	0	36	34	35
2025	11	20	19	52	15	25.7	-2.4	1.094	0.4	0.3	0	38.3	22.4	0	124	86	0	35	34	35
2025	11	20	20	2	15	25.5	-2.1	1.094	0.5	0.4	0	37.8	22.4	0	123	86	0	35	34	35
2025	11	20	20	12	15	25.4	-2.1	1.094	0.3	0.2	0	38.3	22.4	0	123	86	0	34	34	35
2025	11	20	20	22	15	25.7	-2.3	1.095	0.3	0.2	0	37.4	21.5	0	122	84	0	35	34	35
2025	11	20	20	32	15	26.6	-2.7	1.095	0.3	0.2	0	37	21.1	0	122	84	0	36	35	35
2025	11	20	20	42	15	25.6	-2.9	1.095	0.3	0.2	0	37	21.5	0	121	84	0	35	34	35
2025	11	20	20	52	15	25.7	-2.3	1.095	0.4	0.3	0	37	21.1	0	121	83	0	35	34	35
2025	11	20	21	2	15	25.4	-2.6	1.096	0.3	0.2	0	36.5	20.6	0	121	83	0	36	35	34
2025	11	20	21	12	15	25	-2.8	1.096	0.3	0.2	0	36.5	21.1	0	120	83	0	35	34	35
2025	11	20	21	22	15	26.4	-2.5	1.096	0.3	0.2	0	36.5	21.5	0	120	84	0	35	34	35
2025	11	20	21	32	15	25.7	-3.4	1.097	0.4	0.3	0	36.5	21.5	0	120	84	0	35	34	35
2025	11	20	21	42	15	24.9	-2	1.098	0.3	0.2	0	36.5	20.6	0	120	82	0	35	34	35
2025	11	20	21	52	15	25.8	-3.1	1.099	0.4	0.3	0	36.5	20.6	0	119	82	0	34	34	35
2025	11	20	22	2	15	25.4	-1.7	1.099	0.4	0.3	0	36.1	20.6	0	119	82	0	35	34	35
2025	11	20	22	12	15	26.2	-2.9	1.101	0.3	0.2	0	36.1	21.1	0	119	82	0	35	33	35
2025	11	20	22	22	15	25.4	-3.7	1.101	0.4	0.3	0	36.1	20.2	0	119	81	0	35	34	34
2025	11	20	22	32	15	26.2	-2.9	1.101	0.5	0.4	0	35.7	20.2	0	118	81	0	35	34	35
2025	11	20	22	42	15	25.2	-2.4	1.101	0.4	0.3	0	35.7	20.2	0	118	82	0	35	35	35
2025	11	20	22	52	15	25	-3.4	1.101	0.3	0.2	0	35.7	20.2	0	118	81	0	35	34	35
2025	11	20	23	2	15	26.2	-2.4	1.102	0.3	0.2	0	35.7	20.6	0	118	82	0	35	34	35
2025	11	20	23	12	15	26.6	-2.5	1.102	0.3	0.2	0	35.7	20.2	0	118	81	0	35	34	35
2025	11	20	23	22	15	24.4	-3.6	1.102	0.3	0.2	0	35.7	19.8	0	118	81	0	35	35	35
2025	11	20	23	32	15	25.1	-3.5	1.102	0.3	0.2	0	36.1	20.2	0	118	81	0	34	34	35
2025	11	20	23	42	15	26.1	-2.4	1.102	0.4	0.3	0	35.7	20.2	0	118	81	0	35	34	35
2025	11	20	23	52	15	26.1	-3.7	1.102	0.3	0.2	0	35.3	19.8	0	117	81	0	35	35	35

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	11	21	0	2	15	24.7	-1.3	1.102	0.4	0.3	0	35.3	21.1	0	117	82	0	35	33	35	
2025	11	21	0	12	15	25.3	-3	1.102	0.3	0.2	0	35.7	20.2	0	118	81	0	35	34	35	
2025	11	21	0	22	15	23.6	-3.1	1.103	0.4	0.3	0	35.7	19.4	0	118	80	0	35	35	35	
2025	11	21	0	32	15	24.9	-2.9	1.102	0.3	0.2	0	35.7	19.8	0	118	80	0	35	34	35	
2025	11	21	0	42	15	24.5	-2.8	1.102	0.3	0.2	0	36.1	20.6	0	118	82	0	34	34	35	
2025	11	21	0	52	15	26.1	-2.5	1.102	0.3	0.2	0	36.1	20.2	0	118	81	0	34	34	35	
2025	11	21	1	2	15	25.5	-3.3	1.102	0.4	0.3	0	35.3	20.2	0	117	81	0	35	34	35	
2025	11	21	1	12	15	25.7	-2	1.102	0.5	0.4	0	34.8	20.2	0	117	81	0	36	34	35	
2025	11	21	1	22	15	24.5	-1.9	1.102	0.4	0.3	0	35.3	21.1	0	117	82	0	35	33	35	
2025	11	21	1	32	15	24.8	-2.2	1.102	0.3	0.2	0	34.4	20.6	0	116	82	0	36	34	35	
2025	11	21	1	42	15	24	-2.7	1.102	0.3	0.2	0	34.8	20.2	0	117	81	0	36	34	35	
2025	11	21	1	52	15	25.5	-2.9	1.102	0.4	0.3	0	35.3	20.2	0	117	81	0	35	34	35	
2025	11	21	2	2	15	24.9	-2.2	1.102	0.3	0.2	0	35.3	20.6	0	117	81	0	35	33	35	
2025	11	21	2	12	15	23.9	-1.8	1.102	0.4	0.3	0	35.3	20.2	0	117	81	0	35	34	35	
2025	11	21	2	22	15	25.1	-2.4	1.102	0.4	0.3	0	35.3	20.2	0	117	81	0	35	34	35	
2025	11	21	2	32	15	25.2	-2.4	1.102	0.4	0.3	0	35.3	20.2	0	117	81	0	35	34	35	
2025	11	21	2	42	15	24.5	-2	1.102	0.4	0.3	0	35.3	20.6	0	117	82	0	35	34	35	
2025	11	21	2	52	15	24.7	-3.1	1.102	0.4	0.3	0	34.4	20.2	0	116	81	0	36	34	34	
2025	11	21	3	2	15	25.8	-2.9	1.102	0.3	0.2	0	34.8	20.6	0	116	82	0	35	34	35	
2025	11	21	3	12	15	24.5	-1.5	1.102	0.3	0.2	0	34.8	20.2	0	116	81	0	35	34	35	
2025	11	21	3	22	15	25	-2.3	1.102	0.5	0.5	0	34.8	19.8	0	116	81	0	35	35	35	
2025	11	21	3	32	15	26	-1.8	1.102	0.3	0.2	0	34.8	19.8	0	116	80	0	35	34	35	
2025	11	21	3	42	15	25.9	-2.7	1.101	0.3	0.2	0	34.8	19.8	0	116	80	0	35	34	35	
2025	11	21	3	52	15	25.3	-2.7	1.101	0.5	0.5	0	34.8	20.2	0	116	81	0	35	34	35	
2025	11	21	4	2	15	25.1	-2.5	1.101	0.4	0.3	0	34.8	19.8	0	116	80	0	35	34	35	
2025	11	21	4	12	15	26.3	-1.6	1.101	0.4	0.3	0	34.8	20.2	0	116	81	0	35	34	35	
2025	11	21	4	22	15	25.3	-2.1	1.101	0.3	0.2	0	34.8	19.8	0	116	80	0	35	34	35	
2025	11	21	4	32	15	24.9	-2.4	1.101	0.4	0.3	0	34.8	19.8	0	116	80	0	35	34	35	
2025	11	21	4	42	15	25	-2.3	1.101	0.5	0.4	0	34.8	20.2	0	116	81	0	35	34	35	
2025	11	21	4	52	15	24.9	-2.6	1.101	0.3	0.2	0	35.3	20.6	0	116	82	0	34	34	35	
2025	11	21	5	2	15	24.6	-1.4	1.101	0.4	0.3	0	34.8	19.4	0	116	80	0	35	35	35	
2025	11	21	5	12	15	25	-2.5	1.101	0.4	0.3	0	34.8	20.2	0	116	81	0	35	34	35	
2025	11	21	5	22	15	24.7	-1.8	1.101	0.4	0.3	0	34.8	20.2	0	116	81	0	35	34	35	
2025	11	21	5	32	15	24.7	-2	1.101	0.3	0.2	0	34.8	20.6	0	116	82	0	35	34	35	
2025	11	21	5	42	15	25.3	-2.2	1.1	0.3	0.2	0	34.8	20.2	0	116	80	0	35	33	35	
2025	11	21	5	52	15	25.8	-2.1	1.1	0.3	0.2	0	34.8	20.2	0	115	80	0	34	33	35	
2025	11	21	6	2	15	26.7	-3	1.1	0.3	0.2	0	34.8	19.8	0	116	80	0	35	34	34	
2025	11	21	6	12	15	26	-2.1	1.099	0.4	0.3	0	34.4	19.8	0	116	81	0	36	35	35	
2025	11	21	6	22	15	25.5	-2.6	1.1	0.3	0.2	0	34.4	19.8	0	115	80	0	35	34	35	
2025	11	21	6	32	15	25.3	-3.2	1.1	0.4	0.3	0	34.4	19.4	0	115	80	0	35	35	35	
2025	11	21	6	42	15	25.1	-2.7	1.1	0.3	0.2	0	34.8	19.8	0	116	80	0	35	34	35	
2025	11	21	6	52	15	26	-2.6	1.099	0.4	0.3	0	35.3	19.4	0	116	79	0	34	34	35	
2025	11	21	7	2	15	26.7	-3	1.098	0.4	0.3	0	34.8	19.8	0	116	80	0	35	34	34	
2025	11	21	7	12	15	25.4	-1.3	1.097	0.4	0.3	0	34.4	19.8	0	115	80	0	35	34	35	
2025	11	21	7	22	15	25.7	-2.4	1.096	0.5	0.4	0	34.4	20.2	0	116	81	0	36	34	35	
2025	11	21	7	32	15	25.1	-2.7	1.096	0.3	0.2	0	34.4	20.2	0	116	81	0	36	34	35	
2025	11	21	7	42	15	27	-2.5	1.096	0.4	0.3	0	34.8	20.2	0	116	81	0	35	34	35	
2025	11	21	7	52	15	26.5	-2.1	1.096	0.5	0.4	0	34.8	19.8	0	116	80	0	35	34	34	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	21	8	2	15	26.1	-3.6	1.095	0.3	0.2	0	34.8	18.9	0	115	79	0	34	35	35
2025	11	21	8	12	15	24.9	-2.1	1.095	0.4	0.3	0	34	19.4	0	115	80	0	36	35	35
2025	11	21	8	22	15	26.1	-2.2	1.095	0.3	0.2	0	34	19.8	0	114	80	0	35	34	36
2025	11	21	8	32	15	25	-2.9	1.095	0.3	0.2	0	34	19.4	0	114	79	0	35	34	35
2025	11	21	8	42	15	25.6	-2.9	1.095	0.4	0.3	0	34	19.8	0	114	80	0	35	34	35
2025	11	21	8	52	15	25.2	-2.6	1.095	0.3	0.2	0	34	19.4	0	114	79	0	35	34	35
2025	11	21	9	2	15	24.9	-2.6	1.095	0.3	0.2	0	34	19.8	0	114	79	0	35	33	35
2025	11	21	9	12	15	24.7	-2.5	1.095	0.4	0.3	0	33.5	19.4	0	113	79	0	35	34	35
2025	11	21	9	22	15	25.2	-1.8	1.095	0.4	0.3	0	33.1	19.8	0	113	80	0	36	34	35
2025	11	21	9	32	15	25	-1.8	1.095	0.3	0.2	0	33.5	18.9	0	113	79	0	35	35	35
2025	11	21	9	42	15	26.1	-2.2	1.094	0.3	0.2	0	33.1	19.4	0	113	79	0	36	34	35
2025	11	21	9	52	15	24.9	-2.5	1.094	0.3	0.2	0	33.5	18.9	0	113	79	0	35	35	35
2025	11	21	10	2	15	24.9	-2.9	1.094	0.4	0.3	0	33.5	19.4	0	113	79	0	35	34	35
2025	11	21	10	12	15	24.5	-2.1	1.094	0.3	0.2	0	34	20.2	0	114	81	0	35	34	35
2025	11	21	10	22	15	25.3	-1.2	1.094	0.3	0.2	0	34.4	20.2	0	115	81	0	35	34	35
2025	11	21	10	32	15	25.4	-1	1.094	0.3	0.2	0	34	20.2	0	114	80	0	35	33	35
2025	11	21	10	42	15	24.5	-2.1	1.094	0.3	0.2	0	34	20.2	0	114	81	0	35	34	35
2025	11	21	10	52	15	24.9	-1.9	1.094	0.3	0.2	0	34	19.4	0	114	79	0	35	34	35
2025	11	21	11	2	15	25.1	-1.9	1.094	0.3	0.2	0	34	19.4	0	114	79	0	35	34	35
2025	11	21	11	12	15	24.6	-2.1	1.094	0.4	0.3	0	33.5	18.5	0	113	78	0	35	35	35
2025	11	21	11	22	15	23.4	-1.6	1.093	0.3	0.2	0	34	20.2	0	114	80	0	35	33	34
2025	11	21	11	32	15	24	-1.9	1.093	0.3	0.2	0	34	19.8	0	114	80	0	35	34	34
2025	11	21	11	42	15	24.1	-2.5	1.093	0.4	0.3	0	34	19.4	0	114	79	0	35	34	34
2025	11	21	11	52	15	25.7	-3.1	1.093	0.4	0.3	0	34.4	20.2	0	115	81	0	35	34	34
2025	11	21	12	2	15	24.3	-1.7	1.093	0.3	0.2	0	34.8	21.1	0	116	83	0	35	34	35
2025	11	21	12	12	15	25	-1.7	1.093	0.3	0.2	0	34	20.2	0	114	80	0	35	33	34
2025	11	21	12	22	15	25.7	-2.6	1.093	0.5	0.4	0	34	19.4	0	114	79	0	35	34	34
2025	11	21	12	32	15	25.1	-3	1.093	0.4	0.3	0	34	19.8	0	114	80	0	35	34	34
2025	11	21	12	42	15	25.9	-1.7	1.093	0.5	0.4	0	34	19.4	0	114	80	0	35	35	35
2025	11	21	12	52	15	26.6	-1.6	1.093	0.5	0.4	0	33.5	19.4	0	113	79	0	35	34	35
2025	11	21	13	2	15	25.7	-2.3	1.092	0.3	0.2	0	33.1	19.8	0	113	80	0	36	34	35
2025	11	21	13	12	15	24.6	-2.3	1.093	0.4	0.3	0	33.5	19.4	0	113	79	0	35	34	34
2025	11	21	13	22	15	25.3	-1.4	1.092	0.3	0.2	0	33.5	19.8	0	113	79	0	35	33	35
2025	11	21	13	32	15	24.6	-2	1.092	0.3	0.2	0	34	19.8	0	114	80	0	35	34	35
2025	11	21	13	42	15	23.8	-1.9	1.092	0.3	0.2	0	34	19.8	0	114	80	0	35	34	35
2025	11	21	13	52	15	25.1	-2.2	1.092	0.4	0.3	0	33.5	19.8	0	113	80	0	35	34	35
2025	11	21	14	2	15	24.7	-1.6	1.092	0.4	0.3	0	33.5	19.8	0	113	80	0	35	34	34
2025	11	21	14	12	15	24.2	-1.5	1.092	0.3	0.2	0	33.5	19.4	0	113	79	0	35	34	34
2025	11	21	14	22	15	25	-1.7	1.092	0.4	0.3	0	33.5	19.4	0	113	79	0	35	34	35
2025	11	21	14	32	15	25.3	-2.2	1.092	0.3	0.2	0	33.1	19.8	0	113	80	0	36	34	35
2025	11	21	14	42	15	25.6	-1.6	1.092	0.4	0.3	0	33.1	18.9	0	112	79	0	35	35	35
2025	11	21	14	52	15	25	-2.9	1.092	0.3	0.2	0	33.1	19.4	0	112	79	0	35	34	35
2025	11	21	15	2	15	24.7	-1.6	1.092	0.4	0.3	0	33.1	19.4	0	112	79	0	35	34	35
2025	11	21	15	12	15	23	-1.3	1.092	0.4	0.3	0	33.5	19.8	0	113	80	0	35	34	35
2025	11	21	15	22	15	24.6	-1.4	1.092	0.3	0.2	0	33.5	19.8	0	113	80	0	35	34	35
2025	11	21	15	32	15	24.3	-2.4	1.091	0.4	0.3	0	33.5	19.4	0	113	80	0	35	35	35
2025	11	21	15	42	15	23.7	-1.6	1.091	0.4	0.3	0	33.5	19.4	0	113	79	0	35	34	34
2025	11	21	15	52	15	23.4	-2.1	1.091	0.3	0.2	0	33.5	19.4	0	113	79	0	35	34	34

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	11	21	16	2	15	23.3	-2.9	1.091	0.4	0.3	0	33.5	19.4	0	113	79	0	35	34	35	
2025	11	21	16	12	15	23.5	-2.5	1.091	0.3	0.2	0	33.1	19.4	0	112	79	0	35	34	35	
2025	11	21	16	22	15	23.7	-1.8	1.091	0.4	0.3	0	32.7	19.4	0	112	79	0	36	34	35	
2025	11	21	16	32	15	23.9	-1.5	1.091	0.3	0.2	0	33.5	19.4	0	113	79	0	35	34	34	
2025	11	21	16	42	15	22.8	-0.7	1.09	0.4	0.3	0	33.5	19.8	0	113	80	0	35	34	35	
2025	11	21	16	52	15	25.7	-2.6	1.091	0.3	0.2	0	33.5	19.4	0	113	79	0	35	34	35	
2025	11	21	17	2	15	23.7	-1.6	1.09	0.5	0.4	0	33.5	19.4	0	113	79	0	35	34	34	
2025	11	21	17	12	15	23.1	-1.5	1.09	0.4	0.3	0	33.1	19.4	0	113	79	0	36	34	35	
2025	11	21	17	22	15	25	-2	1.09	0.4	0.3	0	33.1	20.2	0	113	80	0	36	33	35	
2025	11	21	17	32	15	24.6	-1.9	1.09	0.4	0.3	0	33.1	19.4	0	112	79	0	35	34	36	
2025	11	21	17	42	15	24.5	-1.6	1.09	0.3	0.2	0	33.1	19.4	0	112	79	0	35	34	34	
2025	11	21	17	52	15	23.5	-1.3	1.09	0.4	0.3	0	33.1	19.4	0	113	80	0	36	35	35	
2025	11	21	18	2	15	22.9	-2.3	1.089	0.5	0.4	0	33.5	19.8	0	113	80	0	35	34	34	
2025	11	21	18	12	15	23.9	-1.3	1.089	0.3	0.2	0	33.1	19.8	0	113	80	0	36	34	35	
2025	11	21	18	22	15	24.6	-1.6	1.089	0.3	0.2	0	34	20.6	0	114	81	0	35	33	34	
2025	11	21	18	32	15	23.3	-1.8	1.089	0.3	0.2	0	34	20.6	0	114	82	0	35	34	35	
2025	11	21	18	42	15	24.5	-1.3	1.089	0.3	0.2	0	34.8	21.5	0	116	84	0	35	34	35	
2025	11	21	18	52	15	24.9	-2.5	1.088	0.3	0.2	0	34.4	21.1	0	115	83	0	35	34	35	
2025	11	21	19	2	15	24.2	-2.3	1.088	0.3	0.2	0	34.4	20.6	0	115	82	0	35	34	35	
2025	11	21	19	12	15	26	-2.1	1.088	0.4	0.3	0	34	20.6	0	114	82	0	35	34	34	
2025	11	21	19	22	15	23.6	-1.3	1.088	0.3	0.2	0	34	20.2	0	114	82	0	35	35	35	
2025	11	21	19	32	15	23.7	-2.5	1.087	0.4	0.3	0	34	21.1	0	114	83	0	35	34	35	
2025	11	21	19	42	15	23.3	-2.3	1.086	0.3	0.2	0	34	20.6	0	114	82	0	35	34	35	
2025	11	21	19	52	15	25.9	-2.7	1.086	0.3	0.2	0	34	21.1	0	114	83	0	35	34	35	
2025	11	21	20	2	15	24.6	-2.2	1.085	0.3	0.2	0	34	20.2	0	114	81	0	35	34	34	
2025	11	21	20	12	15	23.8	-2.9	1.084	0.4	0.3	0	34	21.1	0	115	83	0	36	34	34	
2025	11	21	20	22	15	24.5	-2.7	1.084	0.3	0.2	0	34.4	21.1	0	115	83	0	35	34	34	
2025	11	21	20	32	15	24.9	-2.5	1.084	0.5	0.4	0	34.4	21.1	0	115	83	0	35	34	34	
2025	11	21	20	42	15	25.3	-4.3	1.084	0.3	0.2	0	34.4	21.1	0	115	83	0	35	34	35	
2025	11	21	20	52	15	24.5	-2.6	1.084	0.3	0.2	0	34.4	21.1	0	115	83	0	35	34	35	
2025	11	21	21	2	15	24.6	-3	1.083	0.4	0.3	0	34	21.5	0	115	84	0	36	34	35	
2025	11	21	21	12	15	23.9	-1	1.083	0.4	0.3	0	34.4	21.5	0	115	84	0	35	34	35	
2025	11	21	21	22	15	23.7	-3	1.083	0.5	0.4	0	34.4	21.1	0	115	83	0	35	34	35	
2025	11	21	21	32	15	23.6	-2.9	1.083	0.3	0.2	0	34.4	21.5	0	115	84	0	35	34	35	
2025	11	21	21	42	15	24.4	-1.8	1.083	0.4	0.3	0	34	21.5	0	115	84	0	36	34	35	
2025	11	21	21	52	15	23.3	-1.7	1.083	0.4	0.3	0	34.4	21.1	0	115	83	0	35	34	35	
2025	11	21	22	2	15	24	-1.6	1.082	0.5	0.4	0	34.4	21.1	0	115	83	0	35	34	35	
2025	11	21	22	12	15	24.5	-1.6	1.082	0.3	0.2	0	34	21.1	0	114	83	0	35	34	35	
2025	11	21	22	22	15	24	-1.2	1.082	0.3	0.2	0	34.8	21.5	0	115	84	0	34	34	35	
2025	11	21	22	32	15	24.7	-1.6	1.082	0.3	0.2	0	34	21.5	0	114	84	0	35	34	34	
2025	11	21	22	42	15	26.3	-1.5	1.082	0.3	0.2	0	34	21.1	0	114	83	0	35	34	35	
2025	11	21	22	52	15	24.5	-2	1.082	0.4	0.3	0	33.5	21.1	0	114	83	0	36	34	35	
2025	11	21	23	2	15	24.8	-2.7	1.082	0.5	0.4	0	34	21.5	0	114	84	0	35	34	35	
2025	11	21	23	12	15	24.4	-2.8	1.082	0.5	0.5	0	34	21.5	0	114	84	0	35	34	35	
2025	11	21	23	22	15	23.6	-1.7	1.082	0.5	0.4	0	34.4	21.5	0	115	84	0	35	34	35	
2025	11	21	23	32	15	23.5	-3.3	1.082	0.4	0.3	0	34	21.5	0	114	84	0	35	34	35	
2025	11	21	23	42	15	24.4	-1.5	1.082	0.4	0.3	0	34	21.9	0	114	85	0	35	34	35	
2025	11	21	23	52	15	24.3	-1.9	1.081	0.4	0.3	0	34	21.9	0	114	85	0	35	34	35	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	22	0	2	15	24.4	-1.3	1.081	0.3	0.2	0	34.4	21.9	0	115	84	0	35	33	35
2025	11	22	0	12	15	25.4	-1.8	1.081	0.4	0.3	0	34.4	21.9	0	115	85	0	35	34	35
2025	11	22	0	22	15	24.2	-2.3	1.081	0.4	0.3	0	34	21.9	0	114	85	0	35	34	35
2025	11	22	0	32	15	24.1	-1.7	1.081	0.3	0.2	0	34.4	21.5	0	115	84	0	35	34	34
2025	11	22	0	42	15	24.4	-1	1.081	0.4	0.3	0	34.4	22.4	0	115	86	0	35	34	34
2025	11	22	0	52	15	25.7	-2.5	1.081	0.4	0.3	0	34	21.9	0	114	85	0	35	34	35
2025	11	22	1	2	15	24.5	-1.2	1.081	0.3	0.2	0	34	21.1	0	114	84	0	35	35	35
2025	11	22	1	12	15	23.7	-1.5	1.081	0.3	0.2	0	34	22.4	0	114	85	0	35	33	35
2025	11	22	1	22	15	25.2	-1.3	1.08	0.4	0.3	0	34	21.5	0	114	85	0	35	35	35
2025	11	22	1	32	15	25.3	-2.4	1.08	0.4	0.3	0	34.4	22.4	0	115	85	0	35	33	35
2025	11	22	1	42	15	24.1	-2.5	1.08	0.3	0.2	0	34	21.5	0	114	84	0	35	34	35
2025	11	22	1	52	15	23.4	-1.6	1.08	0.5	0.4	0	34	21.9	0	114	85	0	35	34	35
2025	11	22	2	2	15	24.4	-2	1.08	0.3	0.2	0	34	21.9	0	114	85	0	35	34	35
2025	11	22	2	12	15	24.6	-1.7	1.08	0.4	0.3	0	34	22.4	0	114	85	0	35	33	35
2025	11	22	2	22	15	24.1	-1.5	1.08	0.3	0.2	0	34	21.5	0	114	84	0	35	34	35
2025	11	22	2	32	15	24.4	-2	1.08	0.4	0.3	0	34.4	21.9	0	115	85	0	35	34	35
2025	11	22	2	42	15	25.3	-2.9	1.08	0.5	0.4	0	34	21.9	0	114	85	0	35	34	35
2025	11	22	2	52	15	23.8	-2.4	1.08	0.5	0.4	0	34.4	21.9	0	115	85	0	35	34	35
2025	11	22	3	2	15	25	-2.6	1.08	0.3	0.2	0	34.4	22.4	0	115	85	0	35	33	35
2025	11	22	3	12	15	22.8	-1.7	1.079	0.4	0.3	0	34.4	22.4	0	115	86	0	35	34	35
2025	11	22	3	22	15	25.5	-2.4	1.079	0.4	0.3	0	34.4	22.4	0	115	85	0	35	33	35
2025	11	22	3	32	15	24.9	-2.9	1.079	0.3	0.2	0	34.4	22.4	0	115	86	0	35	34	35
2025	11	22	3	42	15	25.3	-2.9	1.08	0.3	0.2	0	34.4	22.4	0	115	86	0	35	34	34
2025	11	22	3	52	15	24.5	-2.4	1.079	0.4	0.3	0	34.4	22.4	0	115	86	0	35	34	35
2025	11	22	4	2	15	24.5	-2	1.079	0.4	0.3	0	34.8	23.2	0	116	87	0	35	33	35
2025	11	22	4	12	15	26	-2.3	1.079	0.5	0.4	0	34.8	22.4	0	116	86	0	35	34	35
2025	11	22	4	22	15	26	-1.8	1.079	0.3	0.2	0	34.4	21.9	0	115	85	0	35	34	35
2025	11	22	4	32	15	24.8	-2.2	1.078	0.4	0.3	0	34.4	22.4	0	115	86	0	35	34	35
2025	11	22	4	42	15	24.4	-1.5	1.078	0.4	0.3	0	34.8	23.2	0	116	87	0	35	33	35
2025	11	22	4	52	15	25.8	-2.3	1.078	0.5	0.4	0	34.8	22.8	0	116	87	0	35	34	35
2025	11	22	5	2	15	25.5	-2.4	1.078	0.3	0.2	0	34.8	22.4	0	116	86	0	35	34	35
2025	11	22	5	12	15	25.3	-1.7	1.078	0.3	0.2	0	35.3	22.8	0	117	87	0	35	34	35
2025	11	22	5	22	15	25.7	-2.4	1.078	0.4	0.3	0	34.4	22.8	0	116	87	0	36	34	36
2025	11	22	5	32	15	24.5	-2.6	1.078	0.4	0.3	0	34.8	22.8	0	116	87	0	35	34	35
2025	11	22	5	42	15	26.7	-2.8	1.078	0.4	0.3	0	34	22.8	0	115	86	0	36	33	35
2025	11	22	5	52	15	24.3	-1.7	1.078	0.4	0.3	0	34.8	22.4	0	116	86	0	35	34	35
2025	11	22	6	2	15	24.4	-2.3	1.078	0.4	0.3	0	34.8	22.4	0	116	86	0	35	34	35
2025	11	22	6	12	15	25	-2.3	1.078	0.4	0.3	0	34.4	22.8	0	116	87	0	36	34	35
2025	11	22	6	22	15	25.4	-3	1.078	0.5	0.5	0	35.3	23.6	0	117	89	0	35	34	35
2025	11	22	6	32	15	25.7	-2.1	1.078	0.3	0.2	0	34.8	22.8	0	116	87	0	35	34	35
2025	11	22	6	42	15	24.8	-2.1	1.077	0.5	0.4	0	34.4	22.4	0	115	86	0	35	34	35
2025	11	22	6	52	15	24.8	-1.6	1.077	0.4	0.3	0	34.4	22.4	0	115	86	0	35	34	35
2025	11	22	7	2	15	25.5	-2	1.078	0.3	0.2	0	34.8	22.4	0	116	86	0	35	34	35
2025	11	22	7	12	15	26	-2.8	1.078	0.4	0.3	0	34.8	22.4	0	116	86	0	35	34	34
2025	11	22	7	22	15	25.1	-3	1.078	0.5	0.4	0	35.3	22.4	0	116	86	0	34	34	35
2025	11	22	7	32	15	25.8	-3.6	1.078	0.5	0.4	0	34.8	22.8	0	116	87	0	35	34	34
2025	11	22	7	42	15	25.4	-3	1.078	0.4	0.3	0	34.8	22.4	0	116	86	0	35	34	35
2025	11	22	7	52	15	25.3	-3.4	1.077	0.3	0.2	0	34.8	22.4	0	116	86	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	22	8	2	15	24.9	-2.2	1.076	0.4	0.3	0	34.8	22.4	0	116	86	0	35	34	35
2025	11	22	8	12	15	24.1	-2.4	1.077	0.3	0.2	0	34.8	22.4	0	116	86	0	35	34	34
2025	11	22	8	22	15	24	-4.1	1.077	0.4	0.3	0	34.4	22.4	0	115	86	0	35	34	35
2025	11	22	8	32	15	24.3	-3.5	1.077	0.3	0.2	0	34	22.4	0	115	86	0	36	34	34
2025	11	22	8	42	15	24.8	-2.9	1.077	0.5	0.4	0	34.8	22.8	0	116	87	0	35	34	35
2025	11	22	8	52	15	24.9	-1.9	1.077	0.4	0.3	0	34.4	22.4	0	115	86	0	35	34	34
2025	11	22	9	2	15	25.7	-3	1.077	0.5	0.4	0	34	21.9	0	114	85	0	35	34	34
2025	11	22	9	12	15	25.9	-3	1.076	0.4	0.3	0	34	22.4	0	114	86	0	35	34	36
2025	11	22	9	22	15	24.1	-1.9	1.075	0.3	0.2	0	34	21.1	0	114	84	0	35	35	35
2025	11	22	9	32	15	23.8	-3	1.074	0.3	0.2	0	34	21.9	0	114	85	0	35	34	34
2025	11	22	9	42	15	23.7	-2.5	1.075	0.4	0.3	0	34	21.5	0	114	84	0	35	34	35
2025	11	22	9	52	15	25.2	-2.8	1.075	0.3	0.2	0	34	22.4	0	114	85	0	35	33	35
2025	11	22	10	2	15	25.1	-3.2	1.074	0.3	0.2	0	33.5	21.9	0	113	84	0	35	33	35
2025	11	22	10	12	15	25.1	-2.2	1.073	0.4	0.3	0	34	21.9	0	114	85	0	35	34	35
2025	11	22	10	22	15	25.1	-2.4	1.073	0.4	0.3	0	34	21.9	0	114	85	0	35	34	35
2025	11	22	10	32	15	25.3	-1.9	1.073	0.4	0.3	0	34.4	22.4	0	115	86	0	35	34	34
2025	11	22	10	42	15	23.8	-3	1.073	0.3	0.2	0	34	21.9	0	114	85	0	35	34	35
2025	11	22	10	52	15	25.1	-2.7	1.072	0.4	0.3	0	34	21.5	0	114	84	0	35	34	35
2025	11	22	11	2	15	25.4	-2.1	1.073	0.4	0.3	0	34	21.9	0	114	85	0	35	34	34
2025	11	22	11	12	15	25.2	-2.1	1.072	0.4	0.3	0	33.1	21.5	0	113	84	0	36	34	34
2025	11	22	11	22	15	24.8	-2.4	1.072	0.3	0.2	0	33.5	21.5	0	113	84	0	35	34	34
2025	11	22	11	32	15	25.9	-2.4	1.072	0.4	0.3	0	34	21.5	0	114	84	0	35	34	35
2025	11	22	11	42	15	26.4	-1.9	1.072	0.3	0.2	0	33.5	21.9	0	113	85	0	35	34	34
2025	11	22	11	52	15	25.1	-1.7	1.072	0.4	0.3	0	33.5	21.5	0	113	84	0	35	34	35
2025	11	22	12	2	15	24.9	-2.6	1.072	0.5	0.4	0	33.5	21.9	0	113	85	0	35	34	34
2025	11	22	12	12	15	25.1	-2.7	1.072	0.3	0.2	0	33.5	21.5	0	113	84	0	35	34	35
2025	11	22	12	22	15	24	-1.7	1.072	0.3	0.2	0	33.5	21.5	0	113	84	0	35	34	34
2025	11	22	12	32	15	25.9	-2	1.072	0.4	0.3	0	33.5	21.5	0	113	84	0	35	34	35
2025	11	22	12	42	15	26.3	-2.9	1.071	0.3	0.2	0	33.5	21.9	0	113	84	0	35	33	34
2025	11	22	12	52	15	25.8	-1.7	1.071	0.3	0.2	0	34	22.4	0	114	86	0	35	34	35
2025	11	22	13	2	15	25.8	-2	1.071	0.4	0.3	0	33.5	21.9	0	113	85	0	35	34	35
2025	11	22	13	12	15	24.9	-2.3	1.071	0.4	0.3	0	33.5	21.9	0	113	85	0	35	34	35
2025	11	22	13	22	15	25.1	-2.5	1.071	0.4	0.3	0	33.5	21.9	0	113	85	0	35	34	35
2025	11	22	13	32	15	25	-2.4	1.071	0.4	0.3	0	34.4	21.5	0	114	84	0	34	34	34
2025	11	22	13	42	15	25.7	-1.8	1.071	0.5	0.4	0	34	22.4	0	114	85	0	35	33	35
2025	11	22	13	52	15	25.9	-1.9	1.071	0.4	0.3	0	33.5	21.5	0	113	84	0	35	34	35
2025	11	22	14	2	15	25.3	-2.1	1.071	0.5	0.4	0	33.5	22.4	0	113	85	0	35	33	35
2025	11	22	14	12	15	24.5	-3.3	1.071	0.4	0.3	0	33.5	21.9	0	113	85	0	35	34	34
2025	11	22	14	22	15	26.1	-2.5	1.071	0.4	0.3	0	33.1	21.5	0	113	84	0	36	34	35
2025	11	22	14	32	15	24.5	-3.2	1.071	0.3	0.2	0	34	21.9	0	114	85	0	35	34	35
2025	11	22	14	42	15	24.7	-1.8	1.071	0.3	0.2	0	33.5	21.9	0	113	85	0	35	34	35
2025	11	22	14	52	15	25	-3	1.071	0.5	0.4	0	33.5	21.1	0	113	84	0	35	35	35
2025	11	22	15	2	15	24.6	-2.5	1.071	0.4	0.3	0	33.5	21.1	0	113	83	0	35	34	35
2025	11	22	15	12	15	25.4	-3.3	1.071	0.4	0.3	0	33.1	21.5	0	112	84	0	35	34	35
2025	11	22	15	22	15	25.5	-2	1.071	0.3	0.2	0	33.1	21.5	0	112	84	0	35	34	35
2025	11	22	15	32	15	24.6	-2.4	1.071	0.4	0.3	0	33.1	21.5	0	112	83	0	35	33	35
2025	11	22	15	42	15	24.7	-2.9	1.07	0.4	0.3	0	33.1	21.1	0	112	83	0	35	34	35
2025	11	22	15	52	15	26	-2.8	1.071	0.4	0.3	0	33.1	21.5	0	112	84	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	22	16	2	15	24.8	-1.7	1.07	0.4	0.3	0	33.1	21.5	0	112	84	0	35	34	34
2025	11	22	16	12	15	24.2	-2.6	1.07	0.3	0.2	0	33.5	21.9	0	113	84	0	35	33	35
2025	11	22	16	22	15	24.2	-2.3	1.07	0.3	0.2	0	33.5	21.5	0	113	84	0	35	34	35
2025	11	22	16	32	15	25	-2.5	1.071	0.4	0.3	0	33.1	21.5	0	112	84	0	35	34	35
2025	11	22	16	42	15	25	-3.2	1.07	0.5	0.5	0	33.5	21.1	0	113	84	0	35	35	35
2025	11	22	16	52	15	24.5	-3.2	1.07	0.4	0.3	0	33.1	21.5	0	112	84	0	35	34	35
2025	11	22	17	2	15	26	-2.8	1.07	0.4	0.3	0	33.1	21.5	0	112	84	0	35	34	35
2025	11	22	17	12	15	26.4	-3.8	1.07	0.4	0.3	0	33.1	21.1	0	112	83	0	35	34	35
2025	11	22	17	22	15	25	-2.9	1.07	0.5	0.4	0	33.1	21.1	0	112	83	0	35	34	35
2025	11	22	17	32	15	25.3	-2.4	1.07	0.3	0.2	0	32.7	21.5	0	112	84	0	36	34	35
2025	11	22	17	42	15	25.6	-2.7	1.07	0.5	0.4	0	33.1	21.1	0	112	83	0	35	34	35
2025	11	22	17	52	15	24.5	-3.3	1.07	0.3	0.2	0	33.5	21.5	0	113	84	0	35	34	35
2025	11	22	18	2	15	24.8	-2.2	1.07	0.3	0.2	0	33.1	21.5	0	112	84	0	35	34	34
2025	11	22	18	12	15	24.1	-2.5	1.07	0.4	0.3	0	33.5	21.9	0	113	84	0	35	33	35
2025	11	22	18	22	15	24.2	-1.9	1.07	0.4	0.3	0	34	21.9	0	113	85	0	34	34	35
2025	11	22	18	32	15	23.9	-2.8	1.07	0.4	0.3	0	33.5	21.9	0	114	85	0	36	34	35
2025	11	22	18	42	15	25.3	-2.5	1.07	0.5	0.4	0	34	21.9	0	114	85	0	35	34	35
2025	11	22	18	52	15	25.2	-2.9	1.069	0.4	0.3	0	34.4	22.4	0	115	86	0	35	34	35
2025	11	22	19	2	15	25.9	-2	1.07	0.3	0.2	0	34	22.4	0	114	86	0	35	34	35
2025	11	22	19	12	15	24.7	-2.5	1.07	0.3	0.2	0	33.5	21.5	0	114	84	0	36	34	34
2025	11	22	19	22	15	24.4	-2.8	1.069	0.3	0.2	0	34	21.9	0	114	85	0	35	34	35
2025	11	22	19	32	15	24.1	-2.8	1.069	0.4	0.3	0	34.4	22.4	0	115	86	0	35	34	35
2025	11	22	19	42	15	25.1	-3	1.069	0.5	0.5	0	34	21.9	0	114	85	0	35	34	34
2025	11	22	19	52	15	24.1	-2.6	1.069	0.3	0.2	0	34	21.9	0	114	85	0	35	34	35
2025	11	22	20	2	15	24.1	-2.9	1.069	0.4	0.3	0	34.4	21.9	0	115	85	0	35	34	35
2025	11	22	20	12	15	24.5	-2.9	1.069	0.4	0.3	0	34	21.5	0	114	84	0	35	34	35
2025	11	22	20	22	15	25.6	-3.5	1.069	0.4	0.3	0	34.4	21.9	0	115	85	0	35	34	35
2025	11	22	20	32	15	24.9	-2.5	1.069	0.4	0.3	0	34	22.4	0	114	86	0	35	34	34
2025	11	22	20	42	15	25.1	-2.5	1.069	0.4	0.3	0	34	21.9	0	114	85	0	35	34	35
2025	11	22	20	52	15	24.5	-3.2	1.069	0.4	0.3	0	34	21.9	0	114	85	0	35	34	35
2025	11	22	21	2	15	23.7	-2.2	1.069	0.3	0.2	0	34	21.9	0	114	85	0	35	34	35
2025	11	22	21	12	15	24.2	-2.8	1.069	0.4	0.3	0	34	21.9	0	115	85	0	36	34	35
2025	11	22	21	22	15	25.5	-2.6	1.069	0.3	0.2	0	34	21.9	0	114	85	0	35	34	34
2025	11	22	21	32	15	23.8	-2.5	1.069	0.4	0.3	0	34	22.4	0	114	86	0	35	34	34
2025	11	22	21	42	15	24.9	-2.8	1.069	0.3	0.2	0	34	22.4	0	114	85	0	35	33	35
2025	11	22	21	52	15	24.4	-2.6	1.069	0.3	0.2	0	34	21.9	0	114	85	0	35	34	34
2025	11	22	22	2	15	24.6	-1.9	1.069	0.4	0.3	0	34	22.4	0	114	86	0	35	34	35
2025	11	22	22	12	15	23.5	-3.3	1.069	0.4	0.3	0	34	22.8	0	114	86	0	35	33	34
2025	11	22	22	22	15	25.1	-2.4	1.069	0.4	0.3	0	34	22.4	0	114	85	0	35	33	35
2025	11	22	22	32	15	24.7	-3.1	1.068	0.3	0.2	0	33.5	21.9	0	113	85	0	35	34	35
2025	11	22	22	42	15	24.8	-3.5	1.068	0.3	0.2	0	34	21.9	0	114	86	0	35	35	35
2025	11	22	22	52	15	24.6	-2.1	1.068	0.3	0.2	0	34	22.4	0	114	86	0	35	34	35
2025	11	22	23	2	15	24	-2.4	1.068	0.4	0.3	0	34	21.5	0	114	85	0	35	35	35
2025	11	22	23	12	15	24.8	-2.7	1.068	0.3	0.2	0	34	21.9	0	114	85	0	35	34	35
2025	11	22	23	22	15	26.2	-2.9	1.068	0.4	0.3	0	33.5	21.9	0	114	85	0	36	34	35
2025	11	22	23	32	15	25.7	-3	1.068	0.3	0.2	0	34	21.9	0	114	85	0	35	34	35
2025	11	22	23	42	15	24.9	-3.4	1.068	0.3	0.2	0	34	21.9	0	114	85	0	35	34	35
2025	11	22	23	52	15	25	-2.9	1.068	0.3	0.2	0	34	21.9	0	114	85	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	23	0	2	15	24.7	-2.6	1.068	0.3	0.2	0	34.4	21.9	0	115	85	0	35	34	35
2025	11	23	0	12	15	24.1	-2.2	1.068	0.4	0.3	0	34	22.4	0	114	86	0	35	34	34
2025	11	23	0	22	15	25.3	-3.2	1.068	0.4	0.3	0	34	21.9	0	114	86	0	35	35	35
2025	11	23	0	32	15	25.4	-2.9	1.068	0.4	0.3	0	34	21.9	0	114	86	0	35	35	35
2025	11	23	0	42	15	24.5	-2.3	1.068	0.4	0.3	0	34.4	21.9	0	115	86	0	35	35	35
2025	11	23	0	52	15	24.8	-2.9	1.067	0.4	0.3	0	34.4	21.9	0	115	85	0	35	34	35
2025	11	23	1	2	15	25.4	-3.3	1.067	0.4	0.3	0	34.4	21.9	0	114	85	0	34	34	35
2025	11	23	1	12	15	24.5	-2.9	1.067	0.4	0.3	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	1	22	15	24.1	-3.2	1.067	0.4	0.3	0	34	21.9	0	114	85	0	35	34	35
2025	11	23	1	32	15	24.1	-1.8	1.067	0.4	0.3	0	34.4	21.9	0	115	85	0	35	34	35
2025	11	23	1	42	15	22.8	-2.7	1.067	0.3	0.2	0	34.4	22.4	0	115	86	0	35	34	35
2025	11	23	1	52	15	25.6	-3.3	1.067	0.4	0.3	0	34	21.9	0	114	85	0	35	34	35
2025	11	23	2	2	15	23.6	-2.5	1.067	0.4	0.3	0	34	21.9	0	114	85	0	35	34	35
2025	11	23	2	12	15	24.6	-2.9	1.067	0.3	0.2	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	2	22	15	24.9	-3.3	1.067	0.4	0.3	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	2	32	15	23.6	-2.7	1.067	0.4	0.3	0	33.5	22.4	0	114	86	0	36	34	34
2025	11	23	2	42	15	24.9	-3.3	1.067	0.4	0.3	0	34	21.9	0	114	85	0	35	34	35
2025	11	23	2	52	15	24	-2.9	1.066	0.4	0.3	0	34.4	21.9	0	115	85	0	35	34	35
2025	11	23	3	2	15	24.6	-3.3	1.066	0.3	0.2	0	34	21.9	0	114	85	0	35	34	35
2025	11	23	3	12	15	24.1	-3	1.066	0.5	0.4	0	34	21.9	0	114	85	0	35	34	34
2025	11	23	3	22	15	23.6	-3	1.066	0.3	0.2	0	34	21.9	0	114	86	0	35	35	34
2025	11	23	3	32	15	23.9	-2.8	1.066	0.4	0.3	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	3	42	15	23.5	-2.9	1.066	0.5	0.5	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	3	52	15	23.9	-2.9	1.066	0.3	0.2	0	34.4	22.4	0	115	86	0	35	34	35
2025	11	23	4	2	15	23.8	-2.4	1.066	0.5	0.4	0	34.4	22.4	0	115	86	0	35	34	35
2025	11	23	4	12	15	25.1	-1.6	1.066	0.4	0.3	0	34.4	22.8	0	115	87	0	35	34	35
2025	11	23	4	22	15	23.5	-3.3	1.066	0.5	0.4	0	34.4	22.8	0	115	87	0	35	34	35
2025	11	23	4	32	15	24.9	-3.3	1.066	0.4	0.3	0	33.5	21.9	0	114	85	0	36	34	35
2025	11	23	4	42	15	24.5	-3.6	1.066	0.3	0.2	0	34	21.9	0	114	86	0	35	35	34
2025	11	23	4	52	15	25.1	-2.4	1.065	0.3	0.2	0	34	22.8	0	114	87	0	35	34	34
2025	11	23	5	2	15	25.7	-3.2	1.065	0.4	0.3	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	5	12	15	23.8	-2.5	1.066	0.3	0.2	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	5	22	15	24.2	-2.3	1.065	0.4	0.3	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	5	32	15	23.7	-2.3	1.065	0.3	0.2	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	5	42	15	24.8	-2.9	1.065	0.4	0.3	0	34	21.9	0	114	86	0	35	35	35
2025	11	23	5	52	15	24.3	-2.7	1.065	0.3	0.2	0	34	22.8	0	114	86	0	35	33	36
2025	11	23	6	2	15	24.3	-2.4	1.065	0.4	0.3	0	34	22.4	0	114	86	0	35	34	34
2025	11	23	6	12	15	24.2	-2.1	1.065	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	23	6	22	15	24.7	-2	1.065	0.4	0.3	0	33.5	22.4	0	114	86	0	36	34	36
2025	11	23	6	32	15	23.8	-2.4	1.065	0.3	0.2	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	6	42	15	23.8	-3.5	1.065	0.4	0.3	0	34	22.4	0	114	86	0	35	34	34
2025	11	23	6	52	15	24.7	-1.8	1.065	0.5	0.4	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	7	2	15	23.7	-1.8	1.065	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	23	7	12	15	24.6	-2.1	1.065	0.4	0.3	0	33.5	22.4	0	114	86	0	36	34	35
2025	11	23	7	22	15	25.3	-2.9	1.065	0.4	0.3	0	34	21.9	0	114	86	0	35	35	35
2025	11	23	7	32	15	25.2	-2.5	1.065	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	23	7	42	15	24.9	-2.9	1.065	0.5	0.4	0	34.4	22.8	0	115	87	0	35	34	35
2025	11	23	7	52	15	24.1	-2.5	1.064	0.3	0.2	0	34	22.8	0	114	87	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	23	8	2	15	23.8	-1.6	1.064	0.4	0.3	0	34	22.8	0	115	87	0	36	34	35
2025	11	23	8	12	15	25.1	-3.3	1.064	0.4	0.3	0	34	21.9	0	114	86	0	35	35	35
2025	11	23	8	22	15	24.3	-2.9	1.064	0.3	0.2	0	34	22.8	0	114	87	0	35	34	35
2025	11	23	8	32	15	25.9	-2.7	1.064	0.3	0.2	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	8	42	15	25.3	-3.3	1.064	0.4	0.3	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	8	52	15	24.9	-3.7	1.063	0.3	0.2	0	33.5	22.4	0	114	86	0	36	34	35
2025	11	23	9	2	15	24.2	-3.4	1.064	0.5	0.4	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	9	12	15	24.7	-3.7	1.064	0.4	0.3	0	34	22.8	0	114	87	0	35	34	34
2025	11	23	9	22	15	22.9	-1.3	1.063	0.3	0.2	0	34	22.8	0	114	87	0	35	34	35
2025	11	23	9	32	15	24.8	-3	1.063	0.4	0.3	0	33.5	22.4	0	114	86	0	36	34	35
2025	11	23	9	42	15	25.6	-3.5	1.063	0.4	0.3	0	34	21.9	0	114	85	0	35	34	35
2025	11	23	9	52	15	23.9	-3.4	1.062	0.4	0.3	0	33.5	22.4	0	113	86	0	35	34	35
2025	11	23	10	2	15	23.9	-3.7	1.062	0.3	0.2	0	34	22.8	0	114	87	0	35	34	35
2025	11	23	10	12	15	24.5	-3.6	1.062	0.5	0.4	0	34	22.8	0	114	87	0	35	34	35
2025	11	23	10	22	15	25.5	-2.4	1.062	0.4	0.3	0	34.4	22.8	0	115	87	0	35	34	35
2025	11	23	10	32	15	24.9	-3	1.061	0.4	0.3	0	34.4	22.8	0	115	87	0	35	34	35
2025	11	23	10	42	15	23.6	-3.3	1.061	0.3	0.2	0	34	22.4	0	114	87	0	35	35	35
2025	11	23	10	52	15	23.1	-2.9	1.061	0.3	0.2	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	11	2	15	24.6	-4	1.061	0.4	0.3	0	34.4	22.8	0	115	87	0	35	34	35
2025	11	23	11	12	15	24.2	-4.2	1.061	0.5	0.4	0	34	22.4	0	114	86	0	35	34	36
2025	11	23	11	22	15	23.9	-4.4	1.061	0.3	0.2	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	11	32	15	23.8	-2.9	1.06	0.5	0.5	0	33.5	22.4	0	114	86	0	36	34	35
2025	11	23	11	42	15	23.4	-3.4	1.061	0.3	0.2	0	34	22.8	0	114	86	0	35	33	35
2025	11	23	11	52	15	24.7	-2.9	1.06	0.4	0.3	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	12	2	15	23.3	-2.2	1.06	0.3	0.2	0	33.5	21.9	0	113	86	0	35	35	35
2025	11	23	12	12	15	22.6	-2.5	1.06	0.4	0.3	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	12	22	15	22.4	-3	1.06	0.3	0.2	0	33.5	22.4	0	114	86	0	36	34	35
2025	11	23	12	32	15	22.3	-2.6	1.06	0.3	0.2	0	33.5	21.9	0	113	86	0	35	35	35
2025	11	23	12	42	15	23.7	-3.3	1.06	0.4	0.3	0	33.5	22.4	0	113	86	0	35	34	35
2025	11	23	12	52	15	22.6	-3.4	1.06	0.4	0.3	0	33.5	22.4	0	113	86	0	35	34	35
2025	11	23	13	2	15	23.8	-4.8	1.06	0.4	0.3	0	34	22.8	0	115	87	0	36	34	35
2025	11	23	13	12	15	23.3	-3.2	1.06	0.4	0.3	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	13	22	15	24.9	-2.6	1.06	0.5	0.4	0	33.1	22.4	0	113	86	0	36	34	35
2025	11	23	13	32	15	23.1	-2.1	1.06	0.4	0.3	0	33.5	22.4	0	113	86	0	35	34	34
2025	11	23	13	42	15	23	-3.2	1.06	0.3	0.2	0	33.5	22.4	0	113	86	0	35	34	35
2025	11	23	13	52	15	23.9	-2.5	1.06	0.4	0.3	0	33.5	21.9	0	113	85	0	35	34	35
2025	11	23	14	2	15	24.6	-2.8	1.06	0.4	0.3	0	33.5	21.9	0	113	85	0	35	34	35
2025	11	23	14	12	15	24.2	-3.3	1.06	0.4	0.3	0	33.5	22.4	0	113	86	0	35	34	35
2025	11	23	14	22	15	25.3	-3.7	1.06	0.4	0.3	0	33.5	22.4	0	113	86	0	35	34	35
2025	11	23	14	32	15	23.8	-3.7	1.06	0.5	0.4	0	33.5	22.4	0	113	86	0	35	34	35
2025	11	23	14	42	15	24	-2.9	1.059	0.5	0.4	0	33.5	21.9	0	113	86	0	35	35	35
2025	11	23	14	52	15	25.1	-2.4	1.059	0.3	0.2	0	33.1	22.4	0	112	85	0	35	33	35
2025	11	23	15	2	15	23.1	-3.1	1.06	0.4	0.3	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	15	12	15	24.6	-2.5	1.06	0.3	0.2	0	34	21.9	0	113	85	0	34	34	35
2025	11	23	15	22	15	24.2	-2.2	1.06	0.5	0.4	0	33.5	21.9	0	113	86	0	35	35	35
2025	11	23	15	32	15	24.5	-2.4	1.059	0.4	0.3	0	33.5	21.9	0	113	85	0	35	34	35
2025	11	23	15	42	15	23.8	-3.2	1.06	0.4	0.3	0	33.5	21.9	0	113	85	0	35	34	34
2025	11	23	15	52	15	24.4	-2.6	1.059	0.3	0.2	0	33.5	22.4	0	113	86	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	23	16	2	15	25.4	-2.9	1.059	0.4	0.3	0	33.5	21.9	0	113	85	0	35	34	35
2025	11	23	16	12	15	24.9	-2.5	1.059	0.3	0.2	0	33.5	22.4	0	113	86	0	35	34	35
2025	11	23	16	22	15	24.5	-4	1.059	0.5	0.4	0	33.5	21.9	0	113	85	0	35	34	35
2025	11	23	16	32	15	25.8	-3.1	1.059	0.4	0.3	0	33.5	21.9	0	113	85	0	35	34	35
2025	11	23	16	42	15	24.8	-2.9	1.059	0.4	0.3	0	33.5	21.9	0	113	85	0	35	34	35
2025	11	23	16	52	15	23.9	-2.9	1.059	0.4	0.3	0	33.5	21.9	0	113	85	0	35	34	35
2025	11	23	17	2	15	25	-3.4	1.059	0.3	0.2	0	33.5	21.9	0	113	85	0	35	34	34
2025	11	23	17	12	15	25.3	-4.1	1.059	0.4	0.3	0	33.5	21.9	0	113	86	0	35	35	35
2025	11	23	17	22	15	23.4	-3.1	1.059	0.4	0.3	0	33.5	21.9	0	113	85	0	35	34	35
2025	11	23	17	32	15	23.7	-2.5	1.059	0.3	0.2	0	33.5	22.4	0	113	86	0	35	34	34
2025	11	23	17	42	15	24	-2.5	1.059	0.4	0.3	0	33.1	21.9	0	113	85	0	36	34	34
2025	11	23	17	52	15	23.7	-3.3	1.059	0.4	0.3	0	33.5	21.9	0	113	85	0	35	34	34
2025	11	23	18	2	15	24.3	-3.5	1.058	0.4	0.3	0	33.5	21.9	0	113	85	0	35	34	35
2025	11	23	18	12	15	23.7	-3.3	1.058	0.4	0.3	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	18	22	15	24.2	-2.9	1.058	0.5	0.4	0	34	22.8	0	114	86	0	35	33	34
2025	11	23	18	32	15	23.9	-2.5	1.058	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	23	18	42	15	24.7	-2.8	1.058	0.3	0.2	0	34	22.8	0	114	87	0	35	34	35
2025	11	23	18	52	15	24.6	-3	1.058	0.4	0.3	0	34	22.8	0	115	87	0	36	34	35
2025	11	23	19	2	15	23.8	-3.5	1.058	0.3	0.2	0	34.4	23.2	0	115	88	0	35	34	35
2025	11	23	19	12	15	24.1	-2.9	1.058	0.4	0.3	0	34.4	22.8	0	114	87	0	34	34	34
2025	11	23	19	22	15	25.7	-2.9	1.058	0.3	0.2	0	34	22.8	0	114	87	0	35	34	35
2025	11	23	19	32	15	24.9	-3.4	1.057	0.5	0.4	0	34	22.8	0	114	87	0	35	34	34
2025	11	23	19	42	15	25.1	-3.2	1.057	0.5	0.4	0	33.5	22.4	0	114	87	0	36	35	36
2025	11	23	19	52	15	25.3	-3.2	1.057	0.3	0.2	0	34.4	22.8	0	115	87	0	35	34	35
2025	11	23	20	2	15	25.2	-3.3	1.057	0.3	0.2	0	34	23.2	0	114	87	0	35	33	35
2025	11	23	20	12	15	24.1	-2.9	1.057	0.3	0.2	0	34	23.2	0	114	88	0	35	34	35
2025	11	23	20	22	15	23	-4	1.057	0.4	0.3	0	34	23.2	0	114	87	0	35	33	35
2025	11	23	20	32	15	24.4	-3.3	1.057	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	23	20	42	15	25.1	-3.2	1.057	0.3	0.2	0	34	22.8	0	114	87	0	35	34	34
2025	11	23	20	52	15	24.2	-2.1	1.057	0.4	0.3	0	34	22.8	0	114	88	0	35	35	35
2025	11	23	21	2	15	25.7	-2.4	1.057	0.3	0.2	0	34.8	23.6	0	116	89	0	35	34	35
2025	11	23	21	12	15	24.7	-3.3	1.057	0.4	0.3	0	34.4	23.6	0	115	88	0	35	33	35
2025	11	23	21	22	15	24.6	-3.8	1.057	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	23	21	32	15	25.5	-2.9	1.057	0.4	0.3	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	21	42	15	24.1	-2.1	1.056	0.5	0.4	0	34	22.8	0	114	87	0	35	34	34
2025	11	23	21	52	15	24.3	-3	1.056	0.4	0.3	0	34	22.8	0	114	87	0	35	34	34
2025	11	23	22	2	15	24.8	-2.9	1.056	0.3	0.2	0	34	22.8	0	114	87	0	35	34	35
2025	11	23	22	12	15	24.6	-2.9	1.056	0.4	0.3	0	34	22.8	0	114	87	0	35	34	34
2025	11	23	22	22	15	24.6	-2.9	1.056	0.3	0.2	0	34	22.8	0	114	87	0	35	34	35
2025	11	23	22	32	15	23.7	-2.8	1.056	0.5	0.4	0	34	22.8	0	114	87	0	35	34	35
2025	11	23	22	42	15	24.7	-2.8	1.056	0.3	0.2	0	34	22.4	0	114	87	0	35	35	35
2025	11	23	22	52	15	25.2	-3	1.056	0.3	0.2	0	34	22.8	0	114	87	0	35	34	35
2025	11	23	23	2	15	24.1	-3	1.056	0.3	0.2	0	34	22.4	0	114	87	0	35	35	34
2025	11	23	23	12	15	23.8	-3.2	1.056	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	23	23	22	15	24.9	-2.4	1.056	0.3	0.2	0	34	21.9	0	114	86	0	35	35	35
2025	11	23	23	32	15	24.6	-3.5	1.056	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	23	23	42	15	25.6	-3.3	1.056	0.5	0.4	0	34	22.4	0	114	86	0	35	34	35
2025	11	23	23	52	15	25.2	-2.9	1.056	0.4	0.3	0	34	23.2	0	114	87	0	35	33	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	24	0	2	15	25.5	-3.9	1.055	0.3	0.2	0	34	22.4	0	114	86	0	35	34	35
2025	11	24	0	12	15	25.2	-2.9	1.055	0.5	0.5	0	33.5	22.4	0	113	86	0	35	34	35
2025	11	24	0	22	15	24.9	-2.5	1.055	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	0	32	15	25	-3.1	1.055	0.3	0.2	0	34.4	23.2	0	115	88	0	35	34	35
2025	11	24	0	42	15	23.9	-3.3	1.055	0.4	0.3	0	33.5	22.8	0	114	87	0	36	34	35
2025	11	24	0	52	15	24.7	-3.4	1.055	0.3	0.2	0	34	22.4	0	114	87	0	35	35	35
2025	11	24	1	2	15	24	-2.8	1.055	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	1	12	15	24.8	-3.2	1.055	0.4	0.3	0	33.5	23.2	0	114	87	0	36	33	35
2025	11	24	1	22	15	24.1	-2.4	1.055	0.5	0.4	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	1	32	15	24.1	-4.1	1.054	0.4	0.3	0	33.5	22.4	0	113	86	0	35	34	35
2025	11	24	1	42	15	24.9	-2.2	1.055	0.4	0.3	0	34	22.8	0	115	88	0	36	35	35
2025	11	24	1	52	15	25.1	-3.3	1.055	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	2	2	15	25.2	-2.8	1.054	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	2	12	15	24.2	-2.9	1.054	0.4	0.3	0	33.5	22.4	0	113	86	0	35	34	34
2025	11	24	2	22	15	24.3	-2.8	1.054	0.5	0.4	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	2	32	15	24.2	-3.4	1.054	0.3	0.2	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	2	42	15	25	-3.7	1.054	0.3	0.2	0	33.5	22.4	0	113	87	0	35	35	35
2025	11	24	2	52	15	25	-4.1	1.054	0.5	0.4	0	33.1	22.4	0	113	86	0	36	34	35
2025	11	24	3	2	15	24.1	-3.7	1.054	0.4	0.3	0	33.5	22.4	0	113	86	0	35	34	35
2025	11	24	3	12	15	24.4	-3.5	1.054	0.3	0.2	0	34	22.4	0	114	86	0	35	34	35
2025	11	24	3	22	15	23.9	-4.1	1.053	0.5	0.4	0	33.5	23.2	0	113	87	0	35	33	35
2025	11	24	3	32	15	24.2	-3.8	1.053	0.5	0.4	0	34	22.4	0	114	86	0	35	34	35
2025	11	24	3	42	15	25.9	-3.2	1.053	0.5	0.5	0	33.5	22.4	0	113	86	0	35	34	35
2025	11	24	3	52	15	24.7	-4	1.053	0.3	0.2	0	33.5	21.9	0	113	86	0	35	35	35
2025	11	24	4	2	15	24.7	-3.8	1.053	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	4	12	15	24.6	-3.3	1.053	0.3	0.2	0	34	22.4	0	114	86	0	35	34	35
2025	11	24	4	22	15	24.9	-3.5	1.053	0.4	0.3	0	34	22.4	0	114	86	0	35	34	35
2025	11	24	4	32	15	26.3	-3.2	1.053	0.5	0.4	0	34	22.4	0	114	86	0	35	34	35
2025	11	24	4	42	15	24.7	-3.3	1.053	0.5	0.4	0	34	21.9	0	114	86	0	35	35	35
2025	11	24	4	52	15	23.4	-3.7	1.053	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	5	2	15	24.1	-3.7	1.053	0.4	0.3	0	33.5	21.9	0	114	86	0	36	35	35
2025	11	24	5	12	15	24.6	-3.1	1.053	0.3	0.2	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	5	22	15	25.5	-3.3	1.053	0.4	0.3	0	34	22.4	0	114	87	0	35	35	35
2025	11	24	5	32	15	24.4	-3.3	1.052	0.3	0.2	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	5	42	15	24	-3.3	1.052	0.5	0.4	0	34	22.4	0	114	86	0	35	34	35
2025	11	24	5	52	15	24.7	-4.3	1.052	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	6	2	15	24.5	-3.6	1.052	0.3	0.2	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	6	12	15	23.8	-3.7	1.052	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	6	22	15	24.2	-2.9	1.052	0.4	0.3	0	33.5	22.4	0	114	87	0	36	35	36
2025	11	24	6	32	15	25.1	-3.6	1.052	0.3	0.2	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	6	42	15	24.6	-2.8	1.052	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	6	52	15	23.4	-4	1.051	0.3	0.2	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	7	2	15	25	-3.2	1.052	0.3	0.2	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	7	12	15	24.5	-3.9	1.052	0.5	0.4	0	34	22.8	0	114	87	0	35	34	34
2025	11	24	7	22	15	23.7	-3.1	1.052	0.5	0.5	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	7	32	15	24.7	-4.3	1.051	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	7	42	15	23.8	-3.3	1.052	0.4	0.3	0	34	22.4	0	114	87	0	35	35	35
2025	11	24	7	52	15	24.5	-3.9	1.052	0.3	0.2	0	34	22.4	0	114	86	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	24	8	2	15	23.8	-3.9	1.052	0.3	0.2	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	8	12	15	22.2	-3.7	1.051	0.3	0.2	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	8	22	15	24.8	-4.2	1.051	0.5	0.4	0	34	22.8	0	114	86	0	35	33	35
2025	11	24	8	32	15	23.8	-3.9	1.05	0.5	0.4	0	34.4	21.9	0	114	86	0	34	35	35
2025	11	24	8	42	15	24.2	-4	1.05	0.3	0.2	0	33.5	22.8	0	114	87	0	36	34	35
2025	11	24	8	52	15	23.8	-3.3	1.05	0.3	0.2	0	34	22.4	0	114	86	0	35	34	35
2025	11	24	9	2	15	23.8	-3.9	1.051	0.3	0.2	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	9	12	15	23.1	-3.3	1.051	0.3	0.2	0	34.4	23.6	0	116	89	0	36	34	34
2025	11	24	9	22	15	24.4	-2	1.051	0.3	0.2	0	34.4	22.8	0	115	88	0	35	35	35
2025	11	24	9	32	15	24.2	-4	1.05	0.4	0.3	0	34	23.2	0	114	87	0	35	33	35
2025	11	24	9	42	15	23.5	-3.1	1.05	0.3	0.2	0	34.4	22.8	0	115	87	0	35	34	35
2025	11	24	9	52	15	23.8	-3.4	1.049	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	10	2	15	23.4	-4.5	1.049	0.4	0.3	0	33.1	22.4	0	113	86	0	36	34	35
2025	11	24	10	12	15	25.2	-3.8	1.049	0.4	0.3	0	34	22.4	0	113	86	0	34	34	35
2025	11	24	10	22	15	24.7	-4.1	1.049	0.5	0.4	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	24	10	32	15	23.1	-4	1.048	0.4	0.3	0	33.1	22.4	0	113	86	0	36	34	35
2025	11	24	10	42	15	23.2	-3.6	1.048	0.4	0.3	0	34	22.8	0	114	87	0	35	34	35
2025	11	24	10	52	15	23.3	-3.7	1.048	0.3	0.2	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	24	11	2	15	24.3	-4.4	1.048	0.4	0.3	0	33.5	22.4	0	113	86	0	35	34	35
2025	11	24	11	12	15	22.5	-3.7	1.049	0.5	0.5	0	33.1	22.4	0	112	86	0	35	34	35
2025	11	24	11	22	15	23.3	-3.7	1.048	0.3	0.2	0	33.5	22.4	0	113	86	0	35	34	35
2025	11	24	11	32	15	23.1	-4	1.048	0.5	0.4	0	33.1	22.4	0	112	86	0	35	34	35
2025	11	24	11	42	15	23.9	-3.3	1.049	0.4	0.3	0	33.1	22.4	0	112	86	0	35	34	34
2025	11	24	11	52	15	22.8	-3.3	1.049	0.3	0.2	0	33.1	21.9	0	112	86	0	35	35	35
2025	11	24	12	2	15	24.1	-3.7	1.049	0.5	0.4	0	33.5	22.4	0	113	86	0	35	34	35
2025	11	24	12	12	15	24.5	-4.2	1.049	0.3	0.2	0	34.4	23.6	0	115	89	0	35	34	34
2025	11	24	12	22	15	23.1	-3.4	1.049	0.3	0.2	0	34	24.1	0	114	89	0	35	33	35
2025	11	24	12	32	15	22.7	-3.8	1.049	0.3	0.2	0	32.7	21.9	0	112	85	0	36	34	35
2025	11	24	12	42	15	24.5	-4.4	1.049	0.3	0.2	0	32.7	22.4	0	112	86	0	36	34	35
2025	11	24	12	52	15	24.5	-3.4	1.048	0.5	0.4	0	33.1	22.8	0	112	87	0	35	34	35
2025	11	24	13	2	15	23.3	-2.2	1.049	0.4	0.3	0	33.1	22.8	0	112	87	0	35	34	35
2025	11	24	13	12	15	24.4	-3.6	1.049	0.4	0.3	0	32.7	22.4	0	112	86	0	36	34	35
2025	11	24	13	22	15	25.2	-3.6	1.049	0.3	0.2	0	33.1	22.4	0	112	86	0	35	34	35
2025	11	24	13	32	15	24.5	-3.4	1.048	0.5	0.4	0	33.1	22.4	0	112	87	0	35	35	34
2025	11	24	13	42	15	25.4	-4	1.048	0.4	0.3	0	33.1	22.4	0	112	86	0	35	34	34
2025	11	24	13	52	15	25.1	-3.2	1.048	0.4	0.3	0	32.7	22.4	0	112	86	0	36	34	36
2025	11	24	14	2	15	23.9	-3.9	1.048	0.4	0.3	0	33.1	22.8	0	112	87	0	35	34	35
2025	11	24	14	12	15	24.1	-3.1	1.048	0.5	0.4	0	33.5	22.8	0	113	87	0	35	34	36
2025	11	24	14	22	15	24.1	-2.2	1.048	0.5	0.4	0	33.1	22.4	0	113	87	0	36	35	35
2025	11	24	14	32	15	25.3	-3.1	1.047	0.5	0.4	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	24	14	42	15	24.5	-3.1	1.047	0.3	0.2	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	24	14	52	15	23.3	-2.2	1.048	0.4	0.3	0	33.5	22.8	0	113	87	0	35	34	34
2025	11	24	15	2	15	23.1	-3.6	1.047	0.3	0.2	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	24	15	12	15	24.9	-2.9	1.047	0.3	0.2	0	32.7	22.8	0	112	86	0	36	33	35
2025	11	24	15	22	15	23.8	-3	1.047	0.3	0.2	0	33.1	22.4	0	112	86	0	35	34	35
2025	11	24	15	32	15	24.3	-1.9	1.047	0.5	0.4	0	32.7	22.4	0	111	86	0	35	34	35
2025	11	24	15	42	15	23.7	-2.9	1.047	0.4	0.3	0	33.1	22.8	0	112	87	0	35	34	34
2025	11	24	15	52	15	24.5	-3.3	1.047	0.3	0.2	0	34	22.8	0	113	87	0	34	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	24	16	2	15	24.9	-4.1	1.047	0.5	0.4	0	33.5	22.4	0	113	87	0	35	35	35
2025	11	24	16	12	15	23.1	-1.8	1.047	0.3	0.2	0	33.1	22.4	0	112	86	0	35	34	35
2025	11	24	16	22	15	24.4	-3.7	1.047	0.4	0.3	0	34	23.2	0	114	88	0	35	34	35
2025	11	24	16	32	15	24.2	-3.3	1.047	0.3	0.2	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	24	16	42	15	25.8	-4.1	1.048	0.3	0.2	0	34.4	23.6	0	115	89	0	35	34	34
2025	11	24	16	52	15	24.4	-3.3	1.048	0.4	0.3	0	34.4	22.8	0	115	88	0	35	35	35
2025	11	24	17	2	15	23.2	-3.6	1.048	0.3	0.2	0	34	23.2	0	114	88	0	35	34	35
2025	11	24	17	12	15	23.5	-4.2	1.048	0.3	0.2	0	34.4	23.6	0	115	89	0	35	34	35
2025	11	24	17	22	15	24.1	-3.5	1.048	0.5	0.5	0	34	23.2	0	114	88	0	35	34	35
2025	11	24	17	32	15	23.6	-3.3	1.047	0.3	0.2	0	34	23.2	0	114	88	0	35	34	35
2025	11	24	17	42	15	23.9	-4.4	1.047	0.5	0.4	0	34	23.6	0	114	89	0	35	34	35
2025	11	24	17	52	15	24.6	-3.3	1.047	0.5	0.4	0	34.8	24.1	0	116	90	0	35	34	34
2025	11	24	18	2	15	24	-3.3	1.047	0.4	0.3	0	34	23.2	0	114	88	0	35	34	35
2025	11	24	18	12	15	24.9	-3.2	1.047	0.3	0.2	0	34.4	23.2	0	115	88	0	35	34	35
2025	11	24	18	22	15	23.3	-2.9	1.047	0.3	0.2	0	34	22.8	0	114	87	0	35	34	36
2025	11	24	18	32	15	24.4	-3.7	1.047	0.3	0.2	0	34	23.2	0	114	88	0	35	34	35
2025	11	24	18	42	15	25.2	-3.9	1.047	0.4	0.3	0	34	22.8	0	114	87	0	35	34	36
2025	11	24	18	52	15	23.7	-3.3	1.047	0.4	0.3	0	34	23.2	0	114	88	0	35	34	35
2025	11	24	19	2	15	23.8	-2.7	1.047	0.3	0.2	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	24	19	12	15	24.8	-2.9	1.047	0.3	0.2	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	24	19	22	15	24.8	-3.1	1.047	0.4	0.3	0	33.5	22.8	0	113	88	0	35	35	35
2025	11	24	19	32	15	24.1	-2.7	1.047	0.4	0.3	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	24	19	42	15	24.7	-2.5	1.047	0.4	0.3	0	33.5	23.2	0	113	88	0	35	34	34
2025	11	24	19	52	15	24.4	-2.3	1.047	0.5	0.4	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	24	20	2	15	24.9	-3	1.046	0.3	0.2	0	34	24.1	0	114	89	0	35	33	35
2025	11	24	20	12	15	22.2	-2.9	1.046	0.5	0.4	0	34	23.6	0	114	89	0	35	34	35
2025	11	24	20	22	15	23.4	-2.5	1.046	0.5	0.5	0	34	23.2	0	114	88	0	35	34	35
2025	11	24	20	32	15	23	-2.7	1.046	0.4	0.3	0	33.5	23.2	0	114	88	0	36	34	35
2025	11	24	20	42	15	23.8	-3	1.046	0.3	0.2	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	24	20	52	15	23.9	-2.5	1.046	0.4	0.3	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	24	21	2	15	24.1	-2.2	1.046	0.4	0.3	0	34	23.2	0	114	88	0	35	34	35
2025	11	24	21	12	15	23.4	-2.1	1.046	0.3	0.2	0	33.1	23.2	0	113	88	0	36	34	35
2025	11	24	21	22	15	24.9	-3.5	1.046	0.5	0.4	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	24	21	32	15	23.6	-2.5	1.046	0.5	0.5	0	34	23.2	0	114	88	0	35	34	35
2025	11	24	21	42	15	25.8	-3.2	1.046	0.4	0.3	0	34	23.2	0	114	88	0	35	34	35
2025	11	24	21	52	15	24.6	-2.8	1.046	0.4	0.3	0	33.5	22.8	0	114	88	0	36	35	35
2025	11	24	22	2	15	24.3	-2.4	1.046	0.3	0.2	0	33.1	23.2	0	113	87	0	36	33	35
2025	11	24	22	12	15	24.2	-2.4	1.046	0.3	0.2	0	33.5	23.2	0	113	88	0	35	34	36
2025	11	24	22	22	15	23.8	-3	1.045	0.3	0.2	0	32.7	23.2	0	112	88	0	36	34	35
2025	11	24	22	32	15	24	-3.3	1.045	0.4	0.3	0	33.5	22.8	0	113	88	0	35	35	35
2025	11	24	22	42	15	25.5	-3.3	1.045	0.4	0.3	0	32.7	22.8	0	112	87	0	36	34	35
2025	11	24	22	52	15	23.4	-2	1.045	0.3	0.2	0	33.1	22.4	0	112	87	0	35	35	35
2025	11	24	23	2	15	24.1	-2.4	1.045	0.5	0.4	0	33.5	23.2	0	113	88	0	35	34	36
2025	11	24	23	12	15	25.3	-2.4	1.045	0.4	0.3	0	34	23.6	0	114	89	0	35	34	35
2025	11	24	23	22	15	24.2	-3.2	1.045	0.3	0.2	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	24	23	32	15	24	-2.9	1.045	0.4	0.3	0	33.5	22.8	0	113	88	0	35	35	35
2025	11	24	23	42	15	25.5	-3.2	1.045	0.3	0.2	0	33.1	22.8	0	112	87	0	35	34	35
2025	11	24	23	52	15	23.9	-3.3	1.045	0.3	0.2	0	32.7	22.8	0	112	87	0	36	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	25	0	2	15	24.6	-3.4	1.045	0.3	0.2	0	33.1	22.8	0	112	87	0	35	34	35
2025	11	25	0	12	15	25.7	-3	1.045	0.3	0.2	0	33.1	23.2	0	112	88	0	35	34	35
2025	11	25	0	22	15	24.9	-3	1.045	0.4	0.3	0	33.1	23.2	0	112	88	0	35	34	35
2025	11	25	0	32	15	24.7	-2.7	1.045	0.3	0.2	0	33.5	22.8	0	113	88	0	35	35	35
2025	11	25	0	42	15	25.6	-2.9	1.044	0.3	0.2	0	33.5	23.2	0	113	89	0	35	35	36
2025	11	25	0	52	15	24.9	-3.2	1.044	0.4	0.3	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	25	1	2	15	25.2	-3.2	1.045	0.4	0.3	0	33.1	23.2	0	112	88	0	35	34	35
2025	11	25	1	12	15	24.5	-2.5	1.044	0.3	0.2	0	33.1	23.6	0	113	89	0	36	34	35
2025	11	25	1	22	15	26.1	-3.8	1.044	0.4	0.3	0	33.5	23.6	0	113	89	0	35	34	35
2025	11	25	1	32	15	24.9	-2.5	1.044	0.4	0.3	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	25	1	42	15	25.1	-2.1	1.044	0.4	0.3	0	33.1	22.8	0	112	88	0	35	35	35
2025	11	25	1	52	15	25.8	-3.6	1.044	0.5	0.4	0	33.1	23.2	0	112	88	0	35	34	35
2025	11	25	2	2	15	24.9	-2.8	1.044	0.5	0.4	0	33.1	23.2	0	112	88	0	35	34	35
2025	11	25	2	12	15	24.9	-2.5	1.044	0.5	0.4	0	33.5	22.8	0	113	88	0	35	35	35
2025	11	25	2	22	15	24.8	-3.4	1.044	0.5	0.4	0	33.1	23.6	0	113	89	0	36	34	35
2025	11	25	2	32	15	24.4	-3.1	1.044	0.5	0.4	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	25	2	42	15	23.6	-3.2	1.044	0.5	0.4	0	33.1	23.2	0	112	88	0	35	34	35
2025	11	25	2	52	15	24.5	-2.9	1.044	0.3	0.2	0	33.1	22.8	0	112	87	0	35	34	34
2025	11	25	3	2	15	24.4	-3.6	1.044	0.5	0.4	0	32.7	23.2	0	112	88	0	36	34	35
2025	11	25	3	12	15	24.5	-2.4	1.044	0.4	0.3	0	33.1	23.2	0	112	88	0	35	34	35
2025	11	25	3	22	15	24.5	-2.8	1.044	0.4	0.3	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	25	3	32	15	24.9	-3.7	1.044	0.5	0.4	0	33.1	23.2	0	112	88	0	35	34	35
2025	11	25	3	42	15	24.5	-2.9	1.044	0.3	0.2	0	34	23.6	0	114	89	0	35	34	35
2025	11	25	3	52	15	23.6	-2.8	1.044	0.4	0.3	0	34	23.6	0	114	89	0	35	34	35
2025	11	25	4	2	15	25	-3.3	1.044	0.5	0.4	0	34.4	23.6	0	115	89	0	35	34	35
2025	11	25	4	12	15	22.9	-3.8	1.044	0.4	0.3	0	34	23.2	0	114	88	0	35	34	35
2025	11	25	4	22	15	25	-4.1	1.043	0.3	0.2	0	34	23.6	0	114	89	0	35	34	35
2025	11	25	4	32	15	24.1	-2.7	1.044	0.4	0.3	0	33.5	23.6	0	114	89	0	36	34	35
2025	11	25	4	42	15	25.3	-3.2	1.044	0.4	0.3	0	34.8	24.5	0	116	91	0	35	34	35
2025	11	25	4	52	15	23.4	-3.2	1.044	0.3	0.2	0	34.4	24.1	0	115	90	0	35	34	35
2025	11	25	5	2	15	23.1	-2.7	1.043	0.4	0.3	0	34	23.6	0	114	89	0	35	34	35
2025	11	25	5	12	15	23.6	-2.8	1.044	0.3	0.2	0	33.1	23.2	0	113	88	0	36	34	35
2025	11	25	5	22	15	24.7	-2.5	1.044	0.4	0.3	0	34.4	23.6	0	115	89	0	35	34	35
2025	11	25	5	32	15	24.5	-3.5	1.043	0.3	0.2	0	34	23.2	0	114	89	0	35	35	35
2025	11	25	5	42	15	23.6	-3.7	1.043	0.4	0.3	0	33.5	23.6	0	114	89	0	36	34	35
2025	11	25	5	52	15	24.5	-2.7	1.044	0.4	0.3	0	34	23.6	0	114	89	0	35	34	35
2025	11	25	6	2	15	24.1	-3.2	1.043	0.3	0.2	0	33.5	23.2	0	114	88	0	36	34	35
2025	11	25	6	12	15	24.1	-2.3	1.043	0.4	0.3	0	33.5	23.2	0	114	88	0	36	34	35
2025	11	25	6	22	15	24.2	-2.4	1.043	0.4	0.3	0	33.1	23.2	0	113	88	0	36	34	35
2025	11	25	6	32	15	24.1	-2.4	1.043	0.4	0.3	0	33.5	23.2	0	114	88	0	36	34	35
2025	11	25	6	42	15	23	-3.1	1.043	0.3	0.2	0	34	23.2	0	114	88	0	35	34	35
2025	11	25	6	52	15	24.3	-3.4	1.043	0.5	0.4	0	33.5	23.2	0	114	88	0	36	34	35
2025	11	25	7	2	15	24	-3.4	1.043	0.4	0.3	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	25	7	12	15	24.3	-3.2	1.043	0.3	0.2	0	34.4	23.6	0	114	89	0	34	34	35
2025	11	25	7	22	15	24.7	-3	1.043	0.4	0.3	0	34	23.6	0	114	89	0	35	34	35
2025	11	25	7	32	15	25.9	-3.6	1.043	0.3	0.2	0	33.5	23.6	0	113	89	0	35	34	36
2025	11	25	7	42	15	24.4	-4	1.043	0.4	0.3	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	25	7	52	15	23.9	-2.5	1.043	0.4	0.3	0	33.5	23.6	0	114	89	0	36	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	25	8	2	15	24.8	-3.1	1.043	0.5	0.5	0	33.1	23.2	0	113	88	0	36	34	35
2025	11	25	8	12	15	24.9	-3.6	1.043	0.3	0.2	0	34	23.6	0	114	89	0	35	34	35
2025	11	25	8	22	15	22.8	-2.5	1.043	0.5	0.4	0	34	23.6	0	114	89	0	35	34	35
2025	11	25	8	32	15	23.8	-3.7	1.043	0.3	0.2	0	34	23.6	0	115	89	0	36	34	35
2025	11	25	8	42	15	21.9	-2.9	1.043	0.5	0.5	0	33.5	23.2	0	114	89	0	36	35	35
2025	11	25	8	52	15	24.4	-4.5	1.042	0.3	0.2	0	33.5	23.6	0	114	89	0	36	34	35
2025	11	25	9	2	15	24.8	-3.9	1.042	0.3	0.2	0	34	23.6	0	114	89	0	35	34	35
2025	11	25	9	12	15	22.8	-3.4	1.043	0.5	0.4	0	33.5	23.2	0	114	88	0	36	34	35
2025	11	25	9	22	15	23.4	-3.7	1.043	0.3	0.2	0	34	23.2	0	114	88	0	35	34	35
2025	11	25	9	32	15	24.2	-2.8	1.042	0.4	0.3	0	34.4	24.1	0	115	90	0	35	34	35
2025	11	25	9	42	15	23	-3.1	1.043	0.5	0.5	0	34	24.1	0	114	90	0	35	34	35
2025	11	25	9	52	15	23.2	-3.3	1.043	0.4	0.3	0	33.5	23.6	0	113	89	0	35	34	35
2025	11	25	10	2	15	23.8	-2.4	1.043	0.4	0.3	0	34	23.6	0	114	89	0	35	34	36
2025	11	25	10	12	15	23	-2.9	1.043	0.5	0.4	0	34.4	23.6	0	115	90	0	35	35	35
2025	11	25	10	22	15	23.2	-2.6	1.043	0.4	0.3	0	33.5	22.8	0	114	88	0	36	35	35
2025	11	25	10	32	15	22.7	-3.1	1.043	0.4	0.3	0	33.5	22.8	0	114	88	0	36	35	35
2025	11	25	10	42	15	23.7	-3.5	1.043	0.4	0.3	0	34	23.6	0	114	89	0	35	34	35
2025	11	25	10	52	15	23.9	-2.5	1.043	0.3	0.2	0	33.1	23.2	0	113	88	0	36	34	36
2025	11	25	11	2	15	24	-3.1	1.043	0.3	0.2	0	33.1	23.2	0	113	88	0	36	34	35
2025	11	25	11	12	15	22.9	-3	1.043	0.4	0.3	0	33.5	23.6	0	113	88	0	35	33	35
2025	11	25	11	22	15	21.6	-3.1	1.043	0.5	0.4	0	33.1	22.8	0	113	87	0	36	34	35
2025	11	25	11	32	15	22.6	-3.2	1.043	0.4	0.3	0	33.1	22.8	0	113	87	0	36	34	35
2025	11	25	11	42	15	23.2	-3.3	1.043	0.5	0.5	0	33.1	22.4	0	113	87	0	36	35	35
2025	11	25	11	52	15	23.3	-3.2	1.043	0.3	0.2	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	25	12	2	15	23	-2.9	1.043	0.5	0.4	0	33.5	22.4	0	113	87	0	35	35	35
2025	11	25	12	12	15	23.7	-3.9	1.043	0.3	0.2	0	33.5	22.4	0	113	87	0	35	35	35
2025	11	25	12	28	1	23.8	-3.3	1.043	0.4	0.3	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	25	12	38	1	23.6	-4.6	1.043	0.3	0.2	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	25	12	48	1	22.8	-3	1.043	0.4	0.3	0	33.1	22.8	0	112	87	0	35	34	35
2025	11	25	12	58	1	23	-3.6	1.043	0.5	0.4	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	25	13	8	1	23.3	-2.9	1.043	0.3	0.2	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	25	13	18	1	25.1	-3.3	1.043	0.4	0.3	0	34	23.2	0	114	88	0	35	34	35
2025	11	25	13	28	1	22.8	-3.7	1.043	0.4	0.3	0	34.4	24.1	0	116	90	0	36	34	35
2025	11	25	13	38	1	23.1	-3.7	1.043	0.5	0.4	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	25	13	48	1	23.8	-3.7	1.043	0.4	0.3	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	25	13	58	1	23.5	-2.9	1.043	0.4	0.3	0	33.5	23.6	0	114	89	0	36	34	35
2025	11	25	14	8	1	24.7	-2.8	1.043	0.3	0.2	0	34	23.2	0	114	88	0	35	34	35
2025	11	25	14	18	1	23.2	-2.4	1.043	0.5	0.4	0	34	23.2	0	114	88	0	35	34	35
2025	11	25	14	28	1	23.5	-2.7	1.043	0.3	0.2	0	34	23.2	0	114	88	0	35	34	35
2025	11	25	14	38	1	23.1	-1.7	1.043	0.5	0.4	0	33.5	22.8	0	114	88	0	36	35	35
2025	11	25	14	48	1	23.7	-3.1	1.043	0.3	0.2	0	34.8	24.5	0	116	90	0	35	33	35
2025	11	25	14	58	1	23.3	-3.5	1.043	0.5	0.4	0	34.8	23.6	0	116	90	0	35	35	35
2025	11	25	15	8	1	23.4	-3.9	1.043	0.5	0.5	0	34.4	23.6	0	115	89	0	35	34	35
2025	11	25	15	18	1	23.7	-3.3	1.043	0.4	0.3	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	25	15	28	1	24.5	-3.4	1.043	0.4	0.3	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	25	15	38	1	23.1	-4.2	1.043	0.4	0.3	0	33.5	23.2	0	113	87	0	35	33	35
2025	11	25	15	48	1	24.7	-4.1	1.043	0.3	0.2	0	33.1	22.8	0	113	87	0	36	34	35
2025	11	25	15	58	1	23.7	-3.8	1.043	0.3	0.2	0	34.8	23.6	0	116	89	0	35	34	35

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	11	25	16	8	1	25.3	-5.2	1.043	0.3	0.2	0	34	23.6	0	115	89	0	36	34	35	
2025	11	25	16	18	1	24.2	-4	1.043	0.3	0.2	0	34.4	22.8	0	115	88	0	35	35	35	
2025	11	25	16	28	1	23.9	-3.7	1.043	0.3	0.2	0	34	23.2	0	114	88	0	35	34	35	
2025	11	25	16	38	1	24.1	-2.4	1.043	0.4	0.3	0	34.4	23.6	0	115	89	0	35	34	35	
2025	11	25	16	48	1	23.8	-3.6	1.043	0.5	0.4	0	34.4	23.6	0	115	89	0	35	34	34	
2025	11	25	16	58	1	23.3	-3.2	1.043	0.5	0.4	0	34	23.6	0	114	89	0	35	34	34	
2025	11	25	17	8	1	24.7	-3.6	1.042	0.3	0.2	0	34.4	24.1	0	115	90	0	35	34	35	
2025	11	25	17	18	1	23.4	-3.9	1.043	0.5	0.5	0	34.8	23.6	0	116	90	0	35	35	34	
2025	11	25	17	28	1	24.2	-3.3	1.043	0.4	0.3	0	33.5	23.2	0	114	88	0	36	34	35	
2025	11	25	17	38	1	23.5	-2.6	1.043	0.5	0.4	0	34.8	24.1	0	116	90	0	35	34	35	
2025	11	25	17	48	1	24.2	-3.5	1.042	0.3	0.2	0	35.7	24.9	0	118	92	0	35	34	34	
2025	11	25	17	58	1	23.9	-3.8	1.043	0.4	0.3	0	34.4	23.6	0	115	89	0	35	34	35	
2025	11	25	18	8	1	23.7	-3.6	1.042	0.5	0.4	0	34	23.2	0	114	88	0	35	34	35	
2025	11	25	18	18	1	25	-2.7	1.042	0.3	0.2	0	34	23.2	0	114	88	0	35	34	35	
2025	11	25	18	28	1	22.5	-2.9	1.043	0.3	0.2	0	34	23.6	0	114	89	0	35	34	35	
2025	11	25	18	38	1	24.7	-2	1.043	0.5	0.4	0	34	23.6	0	114	89	0	35	34	35	
2025	11	25	18	48	1	24.6	-3	1.042	0.4	0.3	0	34	23.2	0	114	89	0	35	35	35	
2025	11	25	18	58	1	23.3	-2.5	1.042	0.4	0.3	0	34	23.6	0	115	89	0	36	34	35	
2025	11	25	19	8	1	23.4	-3.7	1.042	0.4	0.3	0	34.4	23.6	0	115	89	0	35	34	36	
2025	11	25	19	18	1	22.9	-2.9	1.042	0.5	0.4	0	34	23.2	0	114	89	0	35	35	35	
2025	11	25	19	28	1	25.4	-2.8	1.042	0.4	0.3	0	34	23.2	0	114	88	0	35	34	35	
2025	11	25	19	38	1	24.7	-3.3	1.042	0.4	0.3	0	34	23.2	0	114	88	0	35	34	35	
2025	11	25	19	48	1	23.6	-2.2	1.042	0.4	0.3	0	34	23.2	0	114	89	0	35	35	35	
2025	11	25	19	58	1	23.7	-2	1.042	0.3	0.2	0	33.5	22.8	0	113	88	0	35	35	36	
2025	11	25	20	8	1	23.6	-2.2	1.042	0.3	0.2	0	33.5	23.2	0	113	88	0	35	34	35	
2025	11	25	20	18	1	25.3	-3.7	1.042	0.4	0.3	0	33.5	23.2	0	114	88	0	36	34	35	
2025	11	25	20	28	1	22.8	-2.7	1.042	0.4	0.3	0	33.5	22.4	0	113	87	0	35	35	34	
2025	11	25	20	38	1	23.8	-2.3	1.042	0.3	0.2	0	33.5	22.8	0	113	87	0	35	34	36	
2025	11	25	20	48	1	24.1	-2.5	1.042	0.4	0.3	0	33.1	22.4	0	113	87	0	36	35	35	
2025	11	25	20	58	1	24.3	-3.4	1.041	0.5	0.4	0	33.5	21.9	0	113	86	0	35	35	35	
2025	11	25	21	8	1	25.7	-3	1.041	0.4	0.3	0	34	23.2	0	114	88	0	35	34	35	
2025	11	25	21	18	1	23.7	-2.4	1.041	0.5	0.5	0	33.1	23.2	0	114	88	0	37	34	35	
2025	11	25	21	28	1	23.5	-2.9	1.041	0.5	0.4	0	33.1	22.4	0	113	87	0	36	35	35	
2025	11	25	21	38	1	24.6	-1.6	1.041	0.5	0.4	0	33.1	22.4	0	113	87	0	36	35	35	
2025	11	25	21	48	1	24.2	-2.5	1.041	0.4	0.3	0	33.5	22.4	0	113	87	0	35	35	35	
2025	11	25	21	58	1	25.2	-4.5	1.041	0.3	0.2	0	33.1	22.8	0	113	87	0	36	34	35	
2025	11	25	22	8	1	24.6	-3.4	1.041	0.4	0.3	0	33.5	22.8	0	113	87	0	35	34	35	
2025	11	25	22	18	1	23.6	-3.3	1.041	0.5	0.4	0	33.5	21.9	0	113	86	0	35	35	36	
2025	11	25	22	28	1	24.5	-3.8	1.041	0.4	0.3	0	32.7	22.4	0	112	86	0	36	34	35	
2025	11	25	22	38	1	24	-3.1	1.041	0.4	0.3	0	33.5	22.4	0	113	86	0	35	34	35	
2025	11	25	22	48	1	24.7	-3.2	1.041	0.4	0.3	0	33.1	22.4	0	112	86	0	35	34	34	
2025	11	25	22	58	1	24.4	-4.2	1.041	0.3	0.2	0	32.7	22.4	0	112	86	0	36	34	35	
2025	11	25	23	8	1	24.5	-4	1.041	0.4	0.3	0	33.1	22.8	0	112	87	0	35	34	35	
2025	11	25	23	18	1	23.5	-3.6	1.041	0.3	0.2	0	33.1	22.4	0	112	86	0	35	34	35	
2025	11	25	23	28	1	23.9	-4.7	1.041	0.5	0.4	0	33.1	21.9	0	112	85	0	35	34	35	
2025	11	25	23	38	1	24	-4	1.041	0.3	0.2	0	33.1	21.5	0	112	85	0	35	35	35	
2025	11	25	23	48	1	24	-3.8	1.041	0.4	0.3	0	35.3	24.1	0	117	90	0	35	34	35	
2025	11	25	23	58	1	23.7	-3.7	1.041	0.4	0.3	0	34	23.2	0	115	89	0	36	35	35	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	26	0	8	1	24.5	-4.5	1.041	0.3	0.2	0	34	22.8	0	114	88	0	35	35	36
2025	11	26	0	18	1	23.3	-4.2	1.04	0.4	0.3	0	33.5	22.4	0	113	87	0	35	35	35
2025	11	26	0	28	1	23.2	-4.8	1.041	0.5	0.4	0	33.5	21.9	0	113	86	0	35	35	35
2025	11	26	0	38	1	22.8	-4.2	1.041	0.4	0.3	0	33.1	22.4	0	112	86	0	35	34	35
2025	11	26	0	48	1	23.4	-4.6	1.041	0.5	0.4	0	33.1	21.9	0	112	86	0	35	35	35
2025	11	26	0	58	1	23.3	-3.3	1.04	0.4	0.3	0	33.1	22.4	0	112	86	0	35	34	34
2025	11	26	1	8	1	23.9	-2.8	1.04	0.3	0.2	0	33.1	22.4	0	112	86	0	35	34	35
2025	11	26	1	18	1	24.1	-3.4	1.04	0.4	0.3	0	33.1	22.4	0	112	86	0	35	34	35
2025	11	26	1	28	1	22.7	-4	1.04	0.3	0.2	0	32.3	22.4	0	111	86	0	36	34	35
2025	11	26	1	38	1	22.8	-2.6	1.04	0.5	0.4	0	33.1	22.4	0	112	86	0	35	34	35
2025	11	26	1	48	1	23.1	-3.7	1.04	0.4	0.3	0	33.1	22.4	0	112	86	0	35	34	36
2025	11	26	1	58	1	24.7	-2.8	1.04	0.4	0.3	0	32.7	22.4	0	111	86	0	35	34	35
2025	11	26	2	8	1	23.8	-4.8	1.04	0.3	0.2	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	26	2	18	1	24.4	-4.2	1.04	0.3	0.2	0	32.7	22.4	0	112	87	0	36	35	35
2025	11	26	2	28	1	23.6	-4.2	1.04	0.5	0.5	0	33.1	22.4	0	112	87	0	35	35	35
2025	11	26	2	38	1	23.2	-3.7	1.04	0.4	0.3	0	32.7	22.4	0	112	87	0	36	35	35
2025	11	26	2	48	1	23.3	-3.9	1.04	0.4	0.3	0	32.7	22.8	0	112	87	0	36	34	35
2025	11	26	2	58	1	23.5	-3.5	1.04	0.3	0.2	0	32.7	22.4	0	112	87	0	36	35	35
2025	11	26	3	8	1	24.1	-3.6	1.04	0.4	0.3	0	32.7	22.4	0	112	87	0	36	35	35
2025	11	26	3	18	1	24.2	-3.5	1.04	0.5	0.5	0	33.1	22.8	0	112	87	0	35	34	36
2025	11	26	3	28	1	23.4	-3.7	1.04	0.4	0.3	0	32.7	22.8	0	112	87	0	36	34	35
2025	11	26	3	38	1	25.1	-3.4	1.04	0.5	0.4	0	33.1	22.4	0	112	87	0	35	35	35
2025	11	26	3	48	1	23.9	-3.6	1.04	0.4	0.3	0	33.1	22.8	0	112	87	0	35	34	35
2025	11	26	3	58	1	25.1	-3.6	1.04	0.4	0.3	0	33.1	22.8	0	112	87	0	35	34	35
2025	11	26	4	8	1	23.8	-4	1.04	0.3	0.2	0	33.5	23.6	0	114	89	0	36	34	36
2025	11	26	4	18	1	24.7	-4.1	1.04	0.3	0.2	0	33.5	23.6	0	113	89	0	35	34	36
2025	11	26	4	28	1	24.8	-3.8	1.04	0.3	0.2	0	33.1	22.8	0	112	87	0	35	34	36
2025	11	26	4	38	1	23.2	-3	1.04	0.5	0.4	0	33.1	23.2	0	113	88	0	36	34	35
2025	11	26	4	48	1	24.3	-3.1	1.04	0.4	0.3	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	26	4	58	1	23.2	-2.7	1.04	0.4	0.3	0	32.7	22.8	0	112	87	0	36	34	35
2025	11	26	5	8	1	24	-4.1	1.04	0.4	0.3	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	26	5	18	1	23.1	-4.1	1.04	0.4	0.3	0	33.1	22.4	0	112	87	0	35	35	35
2025	11	26	5	28	1	23.8	-2.6	1.04	0.4	0.3	0	33.1	22.4	0	112	87	0	35	35	35
2025	11	26	5	38	1	24.2	-4.5	1.04	0.4	0.3	0	33.5	23.2	0	113	88	0	35	34	36
2025	11	26	5	48	1	23.1	-3.4	1.04	0.3	0.2	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	26	5	58	1	24.1	-4.5	1.04	0.5	0.4	0	33.5	22.4	0	113	87	0	35	35	35
2025	11	26	6	8	1	23.5	-4.1	1.04	0.4	0.3	0	33.1	22.4	0	112	87	0	35	35	35
2025	11	26	6	18	1	24.3	-3.3	1.04	0.4	0.3	0	33.1	22.8	0	112	87	0	35	34	35
2025	11	26	6	28	1	24	-4.1	1.04	0.3	0.2	0	33.1	22.4	0	112	87	0	35	35	36
2025	11	26	6	38	1	23.6	-3.2	1.04	0.5	0.4	0	33.1	23.2	0	113	88	0	36	34	35
2025	11	26	6	48	1	24.4	-3.9	1.04	0.5	0.4	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	26	6	58	1	23.4	-3.3	1.04	0.3	0.2	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	26	7	8	1	23.9	-3.2	1.04	0.4	0.3	0	33.1	22.8	0	113	87	0	36	34	36
2025	11	26	7	18	1	24.7	-3.5	1.04	0.4	0.3	0	32.7	22.4	0	112	87	0	36	35	36
2025	11	26	7	28	1	24.5	-3.8	1.04	0.4	0.3	0	33.1	22.4	0	113	87	0	36	35	35
2025	11	26	7	38	1	23.2	-3.2	1.04	0.4	0.3	0	32.7	22.4	0	112	87	0	36	35	34
2025	11	26	7	48	1	25	-3.8	1.04	0.4	0.3	0	32.7	22.8	0	112	87	0	36	34	35
2025	11	26	7	58	1	23.2	-3.7	1.04	0.3	0.2	0	33.1	22.8	0	112	87	0	35	34	34

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	11	26	8	8	1	24	-3.8	1.04	0.4	0.3	0	33.1	22.4	0	113	87	0	36	35	35	
2025	11	26	8	18	1	23	-3.8	1.04	0.4	0.3	0	33.1	22.8	0	113	88	0	36	35	35	
2025	11	26	8	28	1	24	-4.3	1.04	0.4	0.3	0	33.1	23.2	0	112	88	0	35	34	36	
2025	11	26	8	38	1	23.5	-3.5	1.04	0.4	0.3	0	33.5	23.2	0	113	88	0	35	34	35	
2025	11	26	8	48	1	24.1	-3.1	1.04	0.3	0.2	0	33.5	22.8	0	113	88	0	35	35	35	
2025	11	26	8	58	1	23.1	-3.1	1.04	0.4	0.3	0	33.1	23.2	0	112	88	0	35	34	35	
2025	11	26	9	8	1	23.1	-3.2	1.04	0.4	0.3	0	33.5	23.2	0	113	88	0	35	34	35	
2025	11	26	9	18	1	23.4	-3.6	1.04	0.3	0.2	0	33.5	23.2	0	114	88	0	36	34	35	
2025	11	26	9	28	1	23.8	-4	1.04	0.4	0.3	0	33.1	22.8	0	112	87	0	35	34	36	
2025	11	26	9	38	1	23.4	-4	1.04	0.3	0.2	0	32.3	22.4	0	111	86	0	36	34	35	
2025	11	26	9	48	1	23.9	-4	1.04	0.5	0.4	0	32.7	22.8	0	112	87	0	36	34	35	
2025	11	26	9	58	1	24.7	-3.5	1.04	0.3	0.2	0	33.1	22.4	0	112	87	0	35	35	35	
2025	11	26	10	8	1	24.7	-4	1.04	0.4	0.3	0	33.5	23.6	0	114	89	0	36	34	35	
2025	11	26	10	18	1	23.6	-5	1.04	0.4	0.3	0	33.5	22.8	0	113	88	0	35	35	35	
2025	11	26	10	28	1	23.8	-3.6	1.04	0.4	0.3	0	34	23.6	0	114	89	0	35	34	35	
2025	11	26	10	38	1	23.3	-3.7	1.04	0.5	0.4	0	34	23.2	0	114	88	0	35	34	35	
2025	11	26	10	48	1	23.5	-4.4	1.04	0.5	0.4	0	33.5	22.8	0	114	88	0	36	35	35	
2025	11	26	10	58	1	22.9	-3.8	1.04	0.3	0.2	0	34	23.2	0	114	88	0	35	34	35	
2025	11	26	11	8	1	23.9	-3.9	1.04	0.5	0.4	0	34.8	24.1	0	116	90	0	35	34	36	
2025	11	26	11	18	1	23.1	-4.4	1.04	0.4	0.3	0	34	23.6	0	115	89	0	36	34	35	
2025	11	26	11	28	1	23.6	-4.1	1.041	0.3	0.2	0	33.5	23.2	0	113	88	0	35	34	35	
2025	11	26	11	38	1	23.4	-3.3	1.041	0.4	0.3	0	33.5	23.2	0	113	88	0	35	34	35	
2025	11	26	11	48	1	24	-3.7	1.041	0.3	0.2	0	32.7	22.8	0	112	87	0	36	34	35	
2025	11	26	11	58	1	23.8	-3.3	1.041	0.5	0.4	0	33.5	22.8	0	113	87	0	35	34	35	
2025	11	26	12	8	1	24	-3.5	1.041	0.4	0.3	0	32.7	22.8	0	112	87	0	36	34	34	
2025	11	26	12	18	1	24.2	-4.8	1.041	0.4	0.3	0	33.5	23.2	0	113	88	0	35	34	35	
2025	11	26	12	28	1	24.5	-3.7	1.041	0.4	0.3	0	33.5	22.8	0	113	87	0	35	34	34	
2025	11	26	12	38	1	24.5	-3	1.041	0.5	0.4	0	34	23.2	0	114	88	0	35	34	35	
2025	11	26	12	48	1	23.4	-3.7	1.041	0.4	0.3	0	33.1	22.8	0	113	87	0	36	34	35	
2025	11	26	12	58	1	24.1	-3.4	1.041	0.4	0.3	0	33.1	22.4	0	112	87	0	35	35	35	
2025	11	26	13	8	1	24.3	-3.7	1.041	0.3	0.2	0	33.1	22.8	0	112	87	0	35	34	35	
2025	11	26	13	18	1	23.2	-3.3	1.041	0.4	0.3	0	32.7	22.4	0	112	87	0	36	35	34	
2025	11	26	13	28	1	22.9	-3.8	1.041	0.5	0.5	0	33.1	22.4	0	112	86	0	35	34	35	
2025	11	26	13	38	1	23.3	-3.3	1.041	0.4	0.3	0	32.7	21.9	0	112	86	0	36	35	36	
2025	11	26	13	48	1	23.7	-3.7	1.041	0.3	0.2	0	32.7	22.4	0	112	86	0	36	34	35	
2025	11	26	13	58	1	23.5	-3.3	1.041	0.4	0.3	0	33.1	22.4	0	112	87	0	35	35	35	
2025	11	26	14	8	1	22.7	-3.4	1.041	0.4	0.3	0	33.1	22.4	0	113	87	0	36	35	35	
2025	11	26	14	18	1	24.1	-2.4	1.041	0.3	0.2	0	33.5	22.8	0	113	87	0	35	34	36	
2025	11	26	14	28	1	23.7	-4.1	1.041	0.4	0.3	0	33.5	22.8	0	113	87	0	35	34	35	
2025	11	26	14	38	1	23	-2.8	1.041	0.3	0.2	0	33.1	22.8	0	112	87	0	35	34	35	
2025	11	26	14	48	1	23.7	-2.7	1.041	0.3	0.2	0	32.7	22.8	0	112	87	0	36	34	35	
2025	11	26	14	58	1	23.5	-3.7	1.041	0.5	0.4	0	32.7	22.8	0	112	87	0	36	34	35	
2025	11	26	15	8	1	23.7	-3.5	1.041	0.4	0.3	0	33.1	22.8	0	112	87	0	35	34	35	
2025	11	26	15	18	1	23.4	-3.2	1.041	0.5	0.4	0	32.7	22.8	0	112	87	0	36	34	35	
2025	11	26	15	28	1	23.8	-2.1	1.041	0.5	0.4	0	33.5	23.2	0	113	88	0	35	34	34	
2025	11	26	15	38	1	23.7	-3	1.041	0.5	0.4	0	33.1	22.4	0	112	87	0	35	35	34	
2025	11	26	15	48	1	23.3	-3.3	1.041	0.3	0.2	0	33.1	22.8	0	112	87	0	35	34	35	
2025	11	26	15	58	1	23.5	-2.8	1.041	0.4	0.3	0	32.7	22.4	0	112	87	0	36	35	35	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	26	16	8	1	23.9	-3.3	1.041	0.5	0.4	0	33.1	22.8	0	112	87	0	35	34	35
2025	11	26	16	18	1	23.2	-2.9	1.041	0.4	0.3	0	33.5	22.4	0	113	87	0	35	35	35
2025	11	26	16	28	1	23.9	-3.2	1.041	0.5	0.5	0	33.5	22.4	0	113	87	0	35	35	35
2025	11	26	16	38	1	23.3	-2.4	1.041	0.3	0.2	0	33.1	23.2	0	113	88	0	36	34	35
2025	11	26	16	48	1	23.1	-2.2	1.041	0.4	0.3	0	33.1	22.4	0	112	87	0	35	35	35
2025	11	26	16	58	1	23.7	-2.9	1.041	0.4	0.3	0	32.7	22.8	0	112	87	0	36	34	36
2025	11	26	17	8	1	23.7	-3.8	1.041	0.4	0.3	0	32.7	22.4	0	111	86	0	35	34	35
2025	11	26	17	18	1	24.8	-3.1	1.041	0.4	0.3	0	33.1	22.8	0	112	87	0	35	34	35
2025	11	26	17	28	1	23.9	-2.5	1.041	0.5	0.4	0	33.5	23.6	0	114	89	0	36	34	35
2025	11	26	17	38	1	23.2	-2.1	1.041	0.5	0.4	0	32.7	22.4	0	112	87	0	36	35	35
2025	11	26	17	48	1	24.5	-3.5	1.041	0.4	0.3	0	32.3	22.4	0	111	86	0	36	34	36
2025	11	26	17	58	1	23.8	-2.4	1.041	0.5	0.5	0	32.7	22.4	0	111	86	0	35	34	35
2025	11	26	18	8	1	22.4	-3.1	1.041	0.4	0.3	0	33.1	22.8	0	112	86	0	35	33	35
2025	11	26	18	18	1	23.9	-2.7	1.041	0.5	0.4	0	33.1	21.9	0	112	86	0	35	35	35
2025	11	26	18	28	1	23.2	-2.3	1.041	0.4	0.3	0	33.5	22.8	0	113	86	0	35	33	35
2025	11	26	18	38	1	23.2	-3.1	1.041	0.3	0.2	0	33.1	22.4	0	113	87	0	36	35	35
2025	11	26	18	48	1	24.3	-3.4	1.041	0.4	0.3	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	26	18	58	1	24.8	-2.4	1.041	0.3	0.2	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	26	19	8	1	24.2	-3.8	1.041	0.4	0.3	0	33.1	22.8	0	113	87	0	36	34	35
2025	11	26	19	18	1	23.9	-3.3	1.041	0.4	0.3	0	33.5	22.8	0	113	87	0	35	34	35
2025	11	26	19	28	1	23.7	-3.5	1.041	0.4	0.3	0	32.7	22.8	0	112	87	0	36	34	35
2025	11	26	19	38	1	23.2	-3.2	1.04	0.5	0.5	0	33.1	22.8	0	113	87	0	36	34	35
2025	11	26	19	48	1	23.2	-3.3	1.041	0.4	0.3	0	33.1	22.8	0	112	87	0	35	34	35
2025	11	26	19	58	1	22.8	-4.1	1.041	0.4	0.3	0	33.1	22.8	0	112	87	0	35	34	35
2025	11	26	20	8	1	23.8	-3.7	1.04	0.5	0.4	0	33.1	22.8	0	113	87	0	36	34	36
2025	11	26	20	18	1	23.6	-2.8	1.041	0.4	0.3	0	33.1	22.4	0	113	87	0	36	35	35
2025	11	26	20	28	1	23.7	-3.3	1.041	0.3	0.2	0	32.7	21.9	0	112	86	0	36	35	34
2025	11	26	20	38	1	24.3	-2.4	1.041	0.5	0.5	0	33.1	21.9	0	113	86	0	36	35	35
2025	11	26	20	48	1	24.6	-2.9	1.041	0.4	0.3	0	33.1	22.4	0	112	86	0	35	34	35
2025	11	26	20	58	1	24.2	-3.6	1.041	0.4	0.3	0	32.7	21.9	0	112	86	0	36	35	35
2025	11	26	21	8	1	24.3	-3.2	1.04	0.3	0.2	0	33.1	22.4	0	112	86	0	35	34	35
2025	11	26	21	18	1	24	-3.2	1.04	0.4	0.3	0	33.1	23.2	0	112	87	0	35	33	36
2025	11	26	21	28	1	23.5	-4.2	1.04	0.4	0.3	0	32.7	22.4	0	112	86	0	36	34	36
2025	11	26	21	38	1	23.5	-2.8	1.04	0.4	0.3	0	32.7	22.8	0	112	87	0	36	34	35
2025	11	26	21	48	1	24.5	-2.5	1.04	0.5	0.4	0	32.3	22.8	0	111	87	0	36	34	35
2025	11	26	21	58	1	23.1	-3.1	1.04	0.4	0.3	0	32.7	22.4	0	112	86	0	36	34	35
2025	11	26	22	8	1	23.6	-2.6	1.04	0.3	0.2	0	32.7	22.4	0	112	86	0	36	34	35
2025	11	26	22	18	1	25.4	-3.7	1.04	0.5	0.4	0	32.7	21.9	0	111	86	0	35	35	34
2025	11	26	22	28	1	23.4	-3.2	1.04	0.3	0.2	0	32.7	21.9	0	112	86	0	36	35	35
2025	11	26	22	38	1	23.5	-3	1.04	0.3	0.2	0	34	23.6	0	114	89	0	35	34	35
2025	11	26	22	48	1	24.4	-2.8	1.04	0.5	0.4	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	26	22	58	1	24	-3.6	1.04	0.4	0.3	0	32.7	21.9	0	112	86	0	36	35	35
2025	11	26	23	8	1	24.7	-3.9	1.04	0.3	0.2	0	33.1	22.4	0	112	86	0	35	34	36
2025	11	26	23	18	1	23.7	-3.2	1.04	0.3	0.2	0	33.1	21.9	0	112	86	0	35	35	34
2025	11	26	23	28	1	26	-2.8	1.04	0.3	0.2	0	32.7	21.9	0	112	86	0	36	35	36
2025	11	26	23	38	1	23.7	-2.2	1.04	0.4	0.3	0	33.1	22.8	0	112	87	0	35	34	35
2025	11	26	23	48	1	24.1	-2.4	1.04	0.3	0.2	0	32.3	22.4	0	111	86	0	36	34	35
2025	11	26	23	58	1	23.4	-2.1	1.04	0.4	0.3	0	32.7	21.9	0	111	86	0	35	35	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	27	0	8	1	22.9	-2.5	1.04	0.3	0.2	0	32.7	21.9	0	111	86	0	35	35	35
2025	11	27	0	18	1	22.9	-4	1.04	0.5	0.4	0	32.7	21.5	0	111	85	0	35	35	35
2025	11	27	0	28	1	23.8	-2.8	1.04	0.5	0.4	0	32.3	22.4	0	111	86	0	36	34	35
2025	11	27	0	38	1	23	-4.3	1.04	0.5	0.4	0	32.7	21.9	0	111	85	0	35	34	36
2025	11	27	0	48	1	24.7	-3.6	1.04	0.4	0.3	0	32.7	22.4	0	111	86	0	35	34	35
2025	11	27	0	58	1	23.8	-3.2	1.04	0.3	0.2	0	32.3	21.5	0	111	85	0	36	35	36
2025	11	27	1	8	1	23.2	-2.8	1.04	0.3	0.2	0	32.7	22.4	0	111	86	0	35	34	35
2025	11	27	1	18	1	25	-3.1	1.04	0.3	0.2	0	32.3	22.4	0	111	86	0	36	34	35
2025	11	27	1	28	1	24.4	-2.9	1.04	0.3	0.2	0	31.8	21.5	0	110	85	0	36	35	35
2025	11	27	1	38	1	24.8	-3.2	1.04	0.4	0.3	0	32.3	22.4	0	111	87	0	36	35	36
2025	11	27	1	48	1	23.7	-2.7	1.04	0.5	0.4	0	33.1	22.8	0	113	87	0	36	34	35
2025	11	27	1	58	1	24.3	-3	1.04	0.3	0.2	0	34.4	24.1	0	115	90	0	35	34	35
2025	11	27	2	8	1	23.3	-3.4	1.04	0.3	0.2	0	33.1	23.2	0	113	88	0	36	34	35
2025	11	27	2	18	1	24.8	-3.8	1.04	0.3	0.2	0	32.7	22.4	0	112	86	0	36	34	35
2025	11	27	2	28	1	24.5	-4.4	1.04	0.3	0.2	0	32.3	21.9	0	111	86	0	36	35	35
2025	11	27	2	38	1	24.4	-3.1	1.04	0.4	0.3	0	32.3	22.4	0	111	86	0	36	34	36
2025	11	27	2	48	1	24.3	-4.3	1.04	0.3	0.2	0	32.3	22.4	0	111	86	0	36	34	35
2025	11	27	2	58	1	24.5	-3.2	1.04	0.4	0.3	0	32.3	21.5	0	111	85	0	36	35	35
2025	11	27	3	8	1	24.5	-3.5	1.04	0.3	0.2	0	32.7	21.5	0	111	85	0	35	35	35
2025	11	27	3	18	1	24.2	-3.2	1.04	0.4	0.3	0	32.3	21.5	0	110	85	0	35	35	35
2025	11	27	3	28	1	24.7	-3.2	1.04	0.4	0.3	0	32.7	21.9	0	111	85	0	35	34	36
2025	11	27	3	38	1	24.6	-2.8	1.04	0.5	0.4	0	32.3	22.4	0	111	86	0	36	34	35
2025	11	27	3	48	1	24.1	-3.5	1.04	0.5	0.4	0	32.7	22.4	0	112	87	0	36	35	35
2025	11	27	3	58	1	24.5	-3.4	1.04	0.3	0.2	0	32.7	22.8	0	112	87	0	36	34	35
2025	11	27	4	8	1	24.7	-3.6	1.04	0.4	0.3	0	32.3	22.4	0	111	87	0	36	35	36
2025	11	27	4	18	1	24.9	-3.2	1.04	0.4	0.3	0	32.7	22.8	0	112	87	0	36	34	35
2025	11	27	4	28	1	23.6	-3.1	1.04	0.5	0.4	0	33.1	22.4	0	112	86	0	35	34	35
2025	11	27	4	38	1	23.2	-2.4	1.04	0.4	0.3	0	33.1	21.9	0	112	86	0	35	35	35
2025	11	27	4	48	1	24.5	-3.4	1.04	0.5	0.4	0	32.7	22.4	0	112	87	0	36	35	35
2025	11	27	4	58	1	25	-2.4	1.04	0.3	0.2	0	32.3	22.4	0	111	86	0	36	34	35
2025	11	27	5	8	1	23.8	-3.3	1.04	0.5	0.4	0	32.7	22.8	0	111	87	0	35	34	36
2025	11	27	5	18	1	25.1	-2.8	1.041	0.4	0.3	0	32.7	22.8	0	111	87	0	35	34	36
2025	11	27	5	28	1	24.6	-2.5	1.04	0.3	0.2	0	32.3	22.8	0	111	87	0	36	34	35
2025	11	27	5	38	1	24.2	-2.6	1.041	0.3	0.2	0	32.7	22.8	0	112	87	0	36	34	35
2025	11	27	5	48	1	23.2	-3.8	1.041	0.3	0.2	0	32.7	22.4	0	112	87	0	36	35	36
2025	11	27	5	58	1	24.6	-3.3	1.041	0.4	0.3	0	32.7	22.8	0	112	87	0	36	34	35
2025	11	27	6	8	1	24.5	-3.2	1.041	0.3	0.2	0	33.1	22.8	0	112	87	0	35	34	35
2025	11	27	6	18	1	23.5	-3.7	1.041	0.4	0.3	0	32.7	22.8	0	112	87	0	36	34	35
2025	11	27	6	28	1	24.1	-3.6	1.04	0.5	0.4	0	32.7	22.4	0	112	86	0	36	34	35
2025	11	27	6	38	1	24.5	-4	1.041	0.4	0.3	0	32.7	22.4	0	111	86	0	35	34	35
2025	11	27	6	48	1	25	-3.9	1.041	0.4	0.3	0	32.7	22.4	0	111	87	0	35	35	35
2025	11	27	6	58	1	24.2	-3.2	1.041	0.4	0.3	0	33.1	22.4	0	112	87	0	35	35	35
2025	11	27	7	8	1	23.6	-2.9	1.041	0.5	0.5	0	32.7	22.8	0	112	87	0	36	34	35
2025	11	27	7	18	1	25	-3.6	1.041	0.5	0.4	0	33.1	22.8	0	112	87	0	35	34	35
2025	11	27	7	28	1	24.9	-3.2	1.041	0.4	0.3	0	32.7	22.4	0	112	87	0	36	35	35
2025	11	27	7	38	1	24.1	-3.3	1.041	0.4	0.3	0	33.1	23.2	0	113	88	0	36	34	35
2025	11	27	7	48	1	23.7	-3.8	1.041	0.3	0.2	0	32.7	22.8	0	112	87	0	36	34	35
2025	11	27	7	58	1	23.8	-2.4	1.042	0.3	0.2	0	33.1	22.8	0	112	88	0	35	35	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	27	8	8	1	23.5	-2.8	1.042	0.3	0.2	0	33.5	22.8	0	113	88	0	35	35	35
2025	11	27	8	18	1	23.7	-2.8	1.042	0.5	0.4	0	33.5	23.2	0	114	88	0	36	34	36
2025	11	27	8	28	1	25.9	-3.5	1.042	0.4	0.3	0	33.1	22.8	0	112	87	0	35	34	35
2025	11	27	8	38	1	24.2	-3.4	1.041	0.3	0.2	0	32.3	22.4	0	111	87	0	36	35	36
2025	11	27	8	48	1	24.6	-3.5	1.042	0.4	0.3	0	33.1	22.4	0	112	86	0	35	34	35
2025	11	27	8	58	1	24.9	-3.1	1.042	0.4	0.3	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	27	9	8	1	23.8	-3	1.042	0.5	0.4	0	33.5	23.2	0	113	88	0	35	34	35
2025	11	27	9	18	1	23.6	-3.4	1.042	0.3	0.2	0	32.7	22.4	0	112	87	0	36	35	35
2025	11	27	9	28	1	23.8	-3.4	1.042	0.4	0.3	0	33.1	22.8	0	112	87	0	35	34	35
2025	11	27	9	38	1	23.6	-2.8	1.042	0.3	0.2	0	33.1	22.4	0	112	87	0	35	35	36
2025	11	27	9	48	1	23.7	-3.8	1.042	0.3	0.2	0	32.3	22.8	0	111	87	0	36	34	34
2025	11	27	9	58	1	24.6	-3.5	1.043	0.5	0.5	0	32.7	21.9	0	110	85	0	34	34	35
2025	11	27	10	8	1	24.2	-3.5	1.043	0.3	0.2	0	31.8	21.9	0	110	86	0	36	35	35
2025	11	27	10	18	1	24.4	-2.8	1.043	0.4	0.3	0	32.7	21.9	0	111	86	0	35	35	35
2025	11	27	10	28	1	24.5	-2.8	1.043	0.4	0.3	0	32.3	22.8	0	111	87	0	36	34	35
2025	11	27	10	38	1	24.7	-3.1	1.043	0.3	0.2	0	32.3	21.9	0	111	86	0	36	35	35
2025	11	27	10	48	1	23.1	-3.2	1.043	0.5	0.5	0	32.3	21.9	0	110	86	0	35	35	35
2025	11	27	10	58	1	24.1	-4	1.043	0.4	0.3	0	32.3	21.9	0	110	85	0	35	34	36
2025	11	27	11	8	1	23.8	-4.5	1.043	0.5	0.4	0	31.8	21.9	0	110	86	0	36	35	35
2025	11	27	11	18	1	23.7	-3.7	1.043	0.4	0.3	0	32.7	22.4	0	111	86	0	35	34	36
2025	11	27	11	28	1	23.6	-3.9	1.043	0.4	0.3	0	32.3	21.9	0	111	86	0	36	35	35
2025	11	27	11	38	1	22.9	-3.7	1.043	0.4	0.3	0	32.7	22.8	0	112	87	0	36	34	35
2025	11	27	11	48	1	24.5	-3.8	1.044	0.3	0.2	0	32.7	22.4	0	111	86	0	35	34	35
2025	11	27	11	58	1	24.2	-4.4	1.044	0.5	0.5	0	32.7	21.9	0	111	86	0	35	35	36
2025	11	27	12	8	1	22.9	-4.6	1.044	0.3	0.2	0	32.7	22.4	0	111	86	0	35	34	35
2025	11	27	12	18	1	23.8	-3.4	1.044	0.5	0.4	0	32.3	22.4	0	111	86	0	36	34	35
2025	11	27	12	28	1	23.6	-4.2	1.044	0.4	0.3	0	32.3	21.9	0	110	85	0	35	34	35
2025	11	27	12	38	1	22.7	-4	1.045	0.3	0.2	0	32.3	21.5	0	110	84	0	35	34	35
2025	11	27	12	48	1	23.9	-4	1.045	0.5	0.4	0	31	21.9	0	107	85	0	35	34	35
2025	11	27	12	58	1	24.6	-3.9	1.044	0.4	0.3	0	32.7	21.9	0	111	86	0	35	35	35
2025	11	27	13	8	1	24.5	-4	1.045	0.4	0.3	0	32.3	21.9	0	110	85	0	35	34	35
2025	11	27	13	18	1	24.4	-3.7	1.045	0.4	0.3	0	31.8	21.9	0	110	85	0	36	34	35
2025	11	27	13	28	1	24.4	-3.2	1.045	0.3	0.2	0	32.3	21.9	0	110	85	0	35	34	35
2025	11	27	13	38	1	23.2	-4	1.045	0.3	0.2	0	32.3	21.9	0	110	85	0	35	34	35
2025	11	27	13	48	1	24.3	-4.8	1.045	0.5	0.4	0	32.3	21.9	0	110	85	0	35	34	35
2025	11	27	13	58	1	25.2	-3	1.045	0.4	0.3	0	31.4	21.9	0	109	85	0	36	34	35
2025	11	27	14	8	1	23.5	-3.6	1.045	0.3	0.2	0	32.3	21.9	0	110	85	0	35	34	35
2025	11	27	14	18	1	24.2	-3.6	1.045	0.4	0.3	0	31.8	21.9	0	109	85	0	35	34	34
2025	11	27	14	28	1	24	-3.5	1.046	0.3	0.2	0	31.8	21.5	0	109	85	0	35	35	35
2025	11	27	14	38	1	23.2	-4.1	1.045	0.5	0.5	0	31.4	21.9	0	109	85	0	36	34	35
2025	11	27	14	48	1	22.8	-4.2	1.046	0.3	0.2	0	31.8	21.5	0	109	84	0	35	34	35
2025	11	27	14	58	1	23.9	-3.3	1.045	0.4	0.3	0	32.3	21.9	0	110	86	0	35	35	35
2025	11	27	15	8	1	24.8	-3.6	1.046	0.4	0.3	0	31.8	22.4	0	110	85	0	36	33	35
2025	11	27	15	18	1	23.7	-2.5	1.046	0.3	0.2	0	31.8	21.9	0	109	85	0	35	34	36
2025	11	27	15	28	1	24	-3.1	1.046	0.3	0.2	0	31.4	21.5	0	109	84	0	36	34	34
2025	11	27	15	38	1	23.6	-2.6	1.046	0.5	0.4	0	31.8	21.1	0	109	84	0	35	35	36
2025	11	27	15	48	1	23.2	-3.8	1.047	0.3	0.2	0	31.8	21.1	0	109	84	0	35	35	35
2025	11	27	15	58	1	24.4	-3.1	1.047	0.4	0.3	0	31.8	21.5	0	109	84	0	35	34	36

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	11	27	16	8	1	24.1	-2.8	1.048	0.4	0.3	0	31.4	21.1	0	109	84	0	36	35	35	
2025	11	27	16	18	1	22.7	-2.5	1.048	0.4	0.3	0	31.4	21.5	0	109	84	0	36	34	35	
2025	11	27	16	28	1	23.1	-3.5	1.049	0.4	0.3	0	31.4	21.1	0	109	84	0	36	35	35	
2025	11	27	16	38	1	24.5	-3.6	1.049	0.3	0.2	0	31.8	21.5	0	109	84	0	35	34	35	
2025	11	27	16	48	1	25.4	-3.1	1.049	0.3	0.2	0	32.3	21.5	0	110	85	0	35	35	35	
2025	11	27	16	58	1	24	-3.8	1.05	0.3	0.2	0	32.3	21.5	0	110	85	0	35	35	35	
2025	11	27	17	8	1	25.1	-2.6	1.05	0.3	0.2	0	31.8	21.5	0	109	84	0	35	34	35	
2025	11	27	17	18	1	24.5	-2.7	1.05	0.4	0.3	0	31.4	21.1	0	108	83	0	35	34	35	
2025	11	27	17	28	1	25.2	-3.3	1.05	0.3	0.2	0	31.8	21.5	0	109	84	0	35	34	35	
2025	11	27	17	38	1	24.8	-3.7	1.05	0.5	0.4	0	31.8	21.1	0	109	83	0	35	34	34	
2025	11	27	17	48	1	23.2	-3.8	1.05	0.3	0.2	0	31.4	21.5	0	109	85	0	36	35	35	
2025	11	27	17	58	1	24.3	-3.1	1.05	0.3	0.2	0	31.8	21.5	0	109	84	0	35	34	35	
2025	11	27	18	8	1	24.3	-3.8	1.05	0.4	0.3	0	31.4	21.5	0	109	84	0	36	34	35	
2025	11	27	18	18	1	24.7	-3	1.05	0.4	0.3	0	31.8	21.5	0	110	84	0	36	34	35	
2025	11	27	18	28	1	24.9	-3.4	1.05	0.3	0.2	0	31.8	21.5	0	110	84	0	36	34	35	
2025	11	27	18	38	1	24.3	-3.3	1.05	0.3	0.2	0	32.7	21.5	0	111	85	0	35	35	35	
2025	11	27	18	48	1	25.9	-3.8	1.05	0.4	0.3	0	32.3	21.9	0	110	85	0	35	34	35	
2025	11	27	18	58	1	24.7	-3.5	1.05	0.3	0.2	0	31.8	21.5	0	110	84	0	36	34	35	
2025	11	27	19	8	1	24.9	-1.8	1.05	0.3	0.2	0	32.3	21.5	0	110	85	0	35	35	35	
2025	11	27	19	18	1	25.1	-4.3	1.05	0.3	0.2	0	32.3	22.4	0	111	86	0	36	34	35	
2025	11	27	19	28	1	24.3	-3.8	1.05	0.4	0.3	0	33.1	22.4	0	112	87	0	35	35	35	
2025	11	27	19	38	1	24.5	-3.6	1.05	0.5	0.4	0	32.7	21.9	0	111	86	0	35	35	35	
2025	11	27	19	48	1	23.8	-3.1	1.05	0.4	0.3	0	32.3	22.4	0	111	87	0	36	35	35	
2025	11	27	19	58	1	24.7	-3.5	1.05	0.4	0.3	0	32.7	22.8	0	111	87	0	35	34	35	
2025	11	27	20	8	1	25.1	-4.1	1.05	0.5	0.4	0	32.3	22.4	0	111	87	0	36	35	35	
2025	11	27	20	18	1	24.8	-3.3	1.05	0.3	0.2	0	32.7	22.8	0	111	87	0	35	34	36	
2025	11	27	20	28	1	25	-3.6	1.05	0.3	0.2	0	32.3	22.8	0	111	87	0	36	34	35	
2025	11	27	20	38	1	24.5	-3.8	1.05	0.5	0.4	0	32.7	22.8	0	111	87	0	35	34	35	
2025	11	27	20	48	1	25	-3.2	1.05	0.4	0.3	0	31.8	22.4	0	110	87	0	36	35	35	
2025	11	27	20	58	1	25.3	-2.8	1.05	0.4	0.3	0	32.3	21.9	0	110	86	0	35	35	36	
2025	11	27	21	8	1	25.4	-4	1.05	0.3	0.2	0	31.8	21.9	0	110	86	0	36	35	36	
2025	11	27	21	18	1	23.8	-3.7	1.05	0.4	0.3	0	31.8	21.9	0	110	86	0	36	35	35	
2025	11	27	21	28	1	24.2	-3.5	1.05	0.5	0.4	0	31.8	21.9	0	110	85	0	36	34	35	
2025	11	27	21	38	1	24.7	-2.6	1.05	0.5	0.4	0	32.3	22.4	0	110	86	0	35	34	35	
2025	11	27	21	48	1	25	-3.6	1.05	0.3	0.2	0	32.3	21.9	0	110	86	0	35	35	36	
2025	11	27	21	58	1	24.4	-2.6	1.05	0.3	0.2	0	32.3	21.9	0	110	86	0	35	35	36	
2025	11	27	22	8	1	24.4	-3.1	1.05	0.3	0.2	0	32.3	22.4	0	110	86	0	35	34	36	
2025	11	27	22	18	1	25	-3.7	1.05	0.3	0.2	0	31.8	22.4	0	109	86	0	35	34	35	
2025	11	27	22	28	1	25.3	-3.5	1.05	0.4	0.3	0	31.8	21.9	0	109	86	0	35	35	36	
2025	11	27	22	38	1	24.5	-3.2	1.05	0.3	0.2	0	31.8	22.4	0	109	86	0	35	34	35	
2025	11	27	22	48	1	24.9	-3.4	1.05	0.4	0.3	0	31.4	21.9	0	109	86	0	36	35	35	
2025	11	27	22	58	1	24.1	-3.6	1.051	0.4	0.3	0	31.4	21.9	0	109	86	0	36	35	35	
2025	11	27	23	8	1	24.8	-3.2	1.05	0.4	0.3	0	31.8	21.5	0	109	85	0	35	35	35	
2025	11	27	23	18	1	25.5	-4	1.05	0.3	0.2	0	31.8	21.9	0	110	86	0	36	35	35	
2025	11	27	23	28	1	25.8	-3.6	1.05	0.3	0.2	0	31.4	22.4	0	109	86	0	36	34	36	
2025	11	27	23	38	1	26.1	-3.8	1.05	0.5	0.4	0	31.8	21.9	0	109	86	0	35	35	35	
2025	11	27	23	48	1	26	-2.6	1.05	0.4	0.3	0	31.8	22.4	0	109	86	0	35	34	35	
2025	11	27	23	58	1	25	-3.4	1.05	0.4	0.3	0	31.8	21.9	0	109	86	0	35	35	35	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	28	0	8	1	24.3	-3.5	1.05	0.4	0.3	0	31.8	22.4	0	109	86	0	35	34	35
2025	11	28	0	18	1	24.9	-3.5	1.05	0.3	0.2	0	31.4	21.9	0	109	86	0	36	35	35
2025	11	28	0	28	1	24.9	-3.6	1.05	0.5	0.4	0	31.4	22.4	0	109	86	0	36	34	35
2025	11	28	0	38	1	24.8	-3.5	1.05	0.3	0.2	0	31.4	21.9	0	109	86	0	36	35	36
2025	11	28	0	48	1	26.2	-3.5	1.05	0.3	0.2	0	31.4	21.9	0	109	85	0	36	34	35
2025	11	28	0	58	1	25.4	-4.4	1.05	0.4	0.3	0	31.8	22.4	0	109	86	0	35	34	36
2025	11	28	1	8	1	23.7	-3.3	1.05	0.4	0.3	0	31.4	21.9	0	109	85	0	36	34	36
2025	11	28	1	18	1	23.4	-2.6	1.05	0.3	0.2	0	32.3	22.8	0	111	87	0	36	34	35
2025	11	28	1	28	1	25.4	-3.2	1.05	0.3	0.2	0	32.7	22.8	0	112	87	0	36	34	36
2025	11	28	1	38	1	24.6	-4.1	1.05	0.4	0.3	0	31.8	22.4	0	110	86	0	36	34	36
2025	11	28	1	48	1	24.7	-3.9	1.05	0.3	0.2	0	31.8	21.5	0	109	85	0	35	35	35
2025	11	28	1	58	1	24.1	-4	1.05	0.4	0.3	0	32.3	21.9	0	110	86	0	35	35	35
2025	11	28	2	8	1	24.8	-3.5	1.05	0.5	0.4	0	32.3	22.4	0	110	86	0	35	34	35
2025	11	28	2	18	1	24.9	-2.8	1.05	0.3	0.2	0	32.3	22.8	0	111	87	0	36	34	35
2025	11	28	2	28	1	24.6	-1.9	1.05	0.4	0.3	0	32.7	22.4	0	112	87	0	36	35	36
2025	11	28	2	38	1	24.6	-3	1.05	0.4	0.3	0	32.3	22.4	0	111	87	0	36	35	35
2025	11	28	2	48	1	24.5	-3.5	1.05	0.3	0.2	0	31.8	21.9	0	110	86	0	36	35	35
2025	11	28	2	58	1	26.2	-3.9	1.05	0.4	0.3	0	31.8	22.4	0	110	86	0	36	34	35
2025	11	28	3	8	1	24.6	-4.1	1.051	0.4	0.3	0	31.4	21.9	0	109	85	0	36	34	36
2025	11	28	3	18	1	25.6	-3.8	1.05	0.3	0.2	0	31.8	21.5	0	109	85	0	35	35	35
2025	11	28	3	28	1	24.7	-2.1	1.051	0.4	0.3	0	31.8	22.4	0	109	86	0	35	34	35
2025	11	28	3	38	1	24.1	-2.7	1.051	0.5	0.4	0	31.4	21.9	0	109	85	0	36	34	35
2025	11	28	3	48	1	24.9	-3.2	1.051	0.3	0.2	0	31.8	22.4	0	109	86	0	35	34	36
2025	11	28	3	58	1	25.3	-4.5	1.051	0.4	0.3	0	31.4	21.9	0	109	85	0	36	34	36
2025	11	28	4	8	1	24.4	-3.4	1.05	0.3	0.2	0	31.8	21.9	0	109	85	0	35	34	35
2025	11	28	4	18	1	25.5	-3.9	1.051	0.3	0.2	0	31.4	21.5	0	109	85	0	36	35	35
2025	11	28	4	28	1	25.3	-3.2	1.051	0.4	0.3	0	31.8	21.5	0	109	85	0	35	35	35
2025	11	28	4	38	1	25	-3.9	1.051	0.3	0.2	0	32.3	21.9	0	110	85	0	35	34	35
2025	11	28	4	48	1	24.5	-3.4	1.051	0.4	0.3	0	32.3	21.9	0	110	85	0	35	34	36
2025	11	28	4	58	1	25.5	-2.8	1.051	0.3	0.2	0	32.3	22.4	0	110	86	0	35	34	35
2025	11	28	5	8	1	24	-2.4	1.051	0.4	0.3	0	31.8	22.4	0	110	86	0	36	34	36
2025	11	28	5	18	1	25.2	-3.6	1.051	0.3	0.2	0	31.4	21.9	0	109	86	0	36	35	35
2025	11	28	5	28	1	25.2	-4.9	1.051	0.5	0.4	0	31.8	22.4	0	109	86	0	35	34	35
2025	11	28	5	38	1	26.6	-3.2	1.051	0.4	0.3	0	31.8	21.9	0	110	85	0	36	34	36
2025	11	28	5	48	1	25.8	-3.5	1.051	0.4	0.3	0	31.8	21.9	0	109	86	0	35	35	35
2025	11	28	5	58	1	24.5	-4.8	1.051	0.4	0.3	0	31.8	21.9	0	109	86	0	35	35	35
2025	11	28	6	8	1	25.4	-3.8	1.051	0.4	0.3	0	31.4	21.1	0	109	84	0	36	35	36
2025	11	28	6	18	1	24.3	-3.6	1.051	0.4	0.3	0	31.4	21.5	0	109	84	0	36	34	36
2025	11	28	6	28	1	23.6	-2.3	1.051	0.4	0.3	0	32.3	21.1	0	110	84	0	35	35	36
2025	11	28	6	38	1	25.2	-3.5	1.051	0.3	0.2	0	31.4	21.1	0	109	84	0	36	35	35
2025	11	28	6	48	1	25.1	-4.8	1.051	0.3	0.2	0	31.4	21.1	0	109	84	0	36	35	36
2025	11	28	6	58	1	24.4	-3.7	1.051	0.4	0.3	0	31.4	21.5	0	109	85	0	36	35	36
2025	11	28	7	8	1	24.7	-2.6	1.051	0.3	0.2	0	31.8	22.4	0	110	86	0	36	34	35
2025	11	28	7	18	1	24.7	-3.1	1.051	0.4	0.3	0	32.3	21.9	0	110	86	0	35	35	35
2025	11	28	7	28	1	25.5	-3.5	1.051	0.4	0.3	0	32.3	22.4	0	110	87	0	35	35	35
2025	11	28	7	38	1	25.1	-2.3	1.051	0.3	0.2	0	32.3	22.8	0	111	87	0	36	34	36
2025	11	28	7	48	1	25.2	-3.1	1.051	0.4	0.3	0	32.3	22.8	0	111	87	0	36	34	35
2025	11	28	7	58	1	25.8	-2.8	1.051	0.3	0.2	0	32.7	22.8	0	111	87	0	35	34	35

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	11	28	8	8	1	25.1	-2.7	1.052	0.4	0.3	0	33.1	22.8	0	112	88	0	35	35	35	
2025	11	28	8	18	1	23.7	-3.9	1.051	0.4	0.3	0	32.7	23.2	0	112	88	0	36	34	35	
2025	11	28	8	28	1	23.6	-3	1.051	0.3	0.2	0	32.7	23.6	0	112	89	0	36	34	35	
2025	11	28	8	38	1	25.2	-3.6	1.051	0.4	0.3	0	33.1	22.8	0	112	88	0	35	35	36	
2025	11	28	8	48	1	24.1	-4.4	1.052	0.4	0.3	0	32.7	23.2	0	112	88	0	36	34	36	
2025	11	28	8	58	1	25	-3.4	1.051	0.5	0.4	0	33.1	23.6	0	112	89	0	35	34	36	
2025	11	28	9	8	1	25.2	-2.3	1.052	0.4	0.3	0	32.3	22.8	0	111	87	0	36	34	35	
2025	11	28	9	18	1	24	-2.4	1.052	0.4	0.3	0	33.1	23.6	0	112	89	0	35	34	36	
2025	11	28	9	28	1	23.5	-3.5	1.052	0.4	0.3	0	33.1	23.6	0	112	89	0	35	34	35	
2025	11	28	9	38	1	24.6	-3	1.052	0.3	0.2	0	33.1	23.2	0	113	89	0	36	35	35	
2025	11	28	9	48	1	23.7	-3.6	1.052	0.3	0.2	0	32.3	22.8	0	110	87	0	35	34	36	
2025	11	28	9	58	1	24.9	-2.9	1.052	0.4	0.3	0	32.3	21.9	0	110	86	0	35	35	35	
2025	11	28	10	8	1	24.5	-3.2	1.052	0.3	0.2	0	32.7	22.8	0	111	87	0	35	34	36	
2025	11	28	10	18	1	25.7	-3.2	1.052	0.3	0.2	0	31.8	21.9	0	110	86	0	36	35	35	
2025	11	28	10	28	1	26	-3.4	1.052	0.5	0.4	0	32.7	23.2	0	111	88	0	35	34	35	
2025	11	28	10	38	1	23.7	-3.2	1.052	0.5	0.5	0	31.8	21.9	0	110	86	0	36	35	35	
2025	11	28	10	48	1	25	-3.1	1.052	0.5	0.4	0	31.8	21.5	0	109	85	0	35	35	35	
2025	11	28	10	58	1	24.9	-3.4	1.052	0.4	0.3	0	31.4	21.1	0	108	84	0	35	35	35	
2025	11	28	11	8	1	25.1	-2.2	1.052	0.3	0.2	0	31.4	21.1	0	108	84	0	35	35	35	
2025	11	28	11	18	1	25	-2.8	1.052	0.4	0.3	0	32.7	22.4	0	111	87	0	35	35	35	
2025	11	28	11	28	1	25.6	-3.5	1.052	0.5	0.4	0	31.8	22.4	0	110	87	0	36	35	36	
2025	11	28	11	38	1	24.7	-3.2	1.052	0.4	0.3	0	31.4	21.9	0	109	85	0	36	34	36	
2025	11	28	11	48	1	24.6	-2.7	1.052	0.3	0.2	0	31.8	21.9	0	109	85	0	35	34	34	
2025	11	28	11	58	1	25.8	-3.5	1.052	0.4	0.3	0	31.4	21.9	0	108	85	0	35	34	35	
2025	11	28	12	8	1	24.4	-3.7	1.053	0.3	0.2	0	31	21.9	0	108	85	0	36	34	36	
2025	11	28	12	18	1	23.7	-3	1.053	0.3	0.2	0	31	21.9	0	108	85	0	36	34	35	
2025	11	28	12	28	1	25.2	-3.4	1.053	0.5	0.4	0	32.3	21.9	0	110	86	0	35	35	36	
2025	11	28	12	38	1	25.6	-2.7	1.053	0.4	0.3	0	32.3	22.8	0	111	87	0	36	34	36	
2025	11	28	12	48	1	25.1	-2.3	1.053	0.3	0.2	0	31.8	22.8	0	110	87	0	36	34	36	
2025	11	28	12	58	1	24.6	-2.8	1.052	0.4	0.3	0	31.8	22.4	0	110	87	0	36	35	35	
2025	11	28	13	8	1	24.7	-2.8	1.052	0.3	0.2	0	31.8	22.8	0	109	87	0	35	34	35	
2025	11	28	13	18	1	24.5	-3.5	1.053	0.5	0.4	0	31.4	22.8	0	109	87	0	36	34	35	
2025	11	28	13	28	1	25.3	-2.7	1.052	0.5	0.4	0	31.8	22.4	0	109	87	0	35	35	35	
2025	11	28	13	38	1	24.3	-2.8	1.053	0.4	0.3	0	32.3	23.2	0	110	88	0	35	34	35	
2025	11	28	13	48	1	25.2	-3.1	1.053	0.4	0.3	0	32.3	22.8	0	111	88	0	36	35	35	
2025	11	28	13	58	1	24	-3.5	1.053	0.4	0.3	0	31.4	22.4	0	109	87	0	36	35	35	
2025	11	28	14	8	1	25	-3.2	1.053	0.4	0.3	0	31.4	21.9	0	109	86	0	36	35	36	
2025	11	28	14	18	1	25	-3	1.053	0.3	0.2	0	31.8	21.9	0	109	85	0	35	34	35	
2025	11	28	14	28	1	23.9	-3.2	1.053	0.4	0.3	0	31	21.9	0	108	85	0	36	34	35	
2025	11	28	14	38	1	24.5	-3.3	1.053	0.3	0.2	0	32.7	23.2	0	111	88	0	35	34	36	
2025	11	28	14	48	1	24.3	-2.5	1.053	0.3	0.2	0	33.1	23.6	0	112	89	0	35	34	36	
2025	11	28	14	58	1	25.2	-3.9	1.053	0.4	0.3	0	31.4	21.9	0	109	86	0	36	35	35	
2025	11	28	15	8	1	24.5	-3.6	1.053	0.3	0.2	0	31.4	21.9	0	108	85	0	35	34	36	
2025	11	28	15	18	1	25.8	-3.8	1.054	0.5	0.4	0	31.4	21.9	0	108	85	0	35	34	36	
2025	11	28	15	28	1	24.4	-3.1	1.053	0.3	0.2	0	31.4	21.9	0	109	85	0	36	34	35	
2025	11	28	15	38	1	25.8	-3.8	1.054	0.4	0.3	0	31	21.5	0	108	84	0	36	34	35	
2025	11	28	15	48	1	24.4	-3.2	1.054	0.3	0.2	0	31	21.5	0	108	85	0	36	35	36	
2025	11	28	15	58	1	24.3	-3.6	1.053	0.3	0.2	0	31.4	21.5	0	108	84	0	35	34	35	

Reinhackle (0365)																					
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3	
2025	11	28	16	8	1	25.1	-3.1	1.053	0.3	0.2	0	31.8	21.9	0	109	85	0	35	34	35	
2025	11	28	16	18	1	25.5	-3.1	1.053	0.5	0.4	0	31.8	21.9	0	109	85	0	35	34	36	
2025	11	28	16	28	1	24.3	-3.2	1.053	0.4	0.3	0	31.4	21.9	0	109	85	0	36	34	35	
2025	11	28	16	38	1	24.2	-3.2	1.053	0.3	0.2	0	31.8	21.5	0	109	85	0	35	35	35	
2025	11	28	16	48	1	25	-3	1.053	0.4	0.3	0	31.4	21.5	0	108	85	0	35	35	35	
2025	11	28	16	58	1	24.1	-3.4	1.053	0.4	0.3	0	31.4	21.9	0	109	85	0	36	34	35	
2025	11	28	17	8	1	23.9	-3.5	1.054	0.5	0.4	0	31.8	22.4	0	110	86	0	36	34	36	
2025	11	28	17	18	1	24.9	-3.4	1.054	0.3	0.2	0	31.4	21.5	0	108	85	0	35	35	36	
2025	11	28	17	28	1	25.4	-4.5	1.053	0.3	0.2	0	31.4	21.1	0	109	84	0	36	35	36	
2025	11	28	17	38	1	24.8	-3.8	1.053	0.4	0.3	0	31	21.5	0	108	84	0	36	34	36	
2025	11	28	17	48	1	24.7	-3.6	1.053	0.4	0.3	0	31.4	21.9	0	108	85	0	35	34	35	
2025	11	28	17	58	1	25.1	-3.7	1.053	0.3	0.2	0	31.8	21.9	0	109	85	0	35	34	35	
2025	11	28	18	8	1	25.1	-3.3	1.053	0.3	0.2	0	31.4	21.5	0	109	85	0	36	35	36	
2025	11	28	18	18	1	24.4	-2.4	1.053	0.4	0.3	0	31.8	21.9	0	109	85	0	35	34	35	
2025	11	28	18	28	1	26	-2.8	1.053	0.3	0.2	0	31.8	21.9	0	109	85	0	35	34	35	
2025	11	28	18	38	1	24.1	-2.8	1.054	0.4	0.3	0	31.8	21.9	0	109	85	0	35	34	36	
2025	11	28	18	48	1	23.9	-3.6	1.054	0.4	0.3	0	31.8	21.9	0	110	86	0	36	35	35	
2025	11	28	18	58	1	23.9	-2.8	1.053	0.3	0.2	0	31.8	22.4	0	110	86	0	36	34	36	
2025	11	28	19	8	1	26.2	-3.4	1.053	0.4	0.3	0	32.3	21.5	0	110	85	0	35	35	35	
2025	11	28	19	18	1	25.3	-3.2	1.053	0.4	0.3	0	31.4	21.9	0	109	85	0	36	34	35	
2025	11	28	19	28	1	25.5	-3.9	1.053	0.3	0.2	0	31.8	21.9	0	109	85	0	35	34	35	
2025	11	28	19	38	1	24.8	-3.2	1.053	0.5	0.4	0	32.3	22.4	0	110	87	0	35	35	35	
2025	11	28	19	48	1	25.4	-2.8	1.053	0.3	0.2	0	32.3	22.8	0	110	87	0	35	34	36	
2025	11	28	19	58	1	25	-2.4	1.053	0.3	0.2	0	31.8	22.8	0	110	87	0	36	34	35	
2025	11	28	20	8	1	26.3	-3.7	1.053	0.4	0.3	0	31.8	22.4	0	110	87	0	36	35	36	
2025	11	28	20	18	1	24.7	-2.9	1.053	0.3	0.2	0	32.3	21.9	0	110	86	0	35	35	35	
2025	11	28	20	28	1	24.6	-2.4	1.053	0.3	0.2	0	31.8	21.9	0	110	86	0	36	35	35	
2025	11	28	20	38	1	24.6	-3.6	1.053	0.4	0.3	0	31.8	22.4	0	110	86	0	36	34	35	
2025	11	28	20	48	1	25.6	-3.5	1.053	0.3	0.2	0	32.3	22.4	0	110	86	0	35	34	35	
2025	11	28	20	58	1	25.1	-3	1.053	0.4	0.3	0	32.3	22.4	0	110	86	0	35	34	36	
2025	11	28	21	8	1	24.5	-2.7	1.053	0.4	0.3	0	31.8	21.9	0	110	86	0	36	35	35	
2025	11	28	21	18	1	25	-3.4	1.053	0.4	0.3	0	32.3	21.9	0	110	86	0	35	35	35	
2025	11	28	21	28	1	25.3	-4	1.053	0.3	0.2	0	32.3	21.9	0	110	86	0	35	35	35	
2025	11	28	21	38	1	24.2	-3.9	1.053	0.5	0.4	0	32.3	22.4	0	110	86	0	35	34	35	
2025	11	28	21	48	1	24.8	-3.2	1.053	0.5	0.4	0	31.8	22.4	0	109	86	0	35	34	36	
2025	11	28	21	58	1	25.1	-3.8	1.053	0.3	0.2	0	31.4	21.9	0	109	86	0	36	35	36	
2025	11	28	22	8	1	24.3	-4.1	1.053	0.4	0.3	0	31.8	21.9	0	110	86	0	36	35	35	
2025	11	28	22	18	1	25.7	-3.1	1.052	0.3	0.2	0	31.8	21.9	0	110	86	0	36	35	35	
2025	11	28	22	28	1	24.2	-3.4	1.052	0.5	0.4	0	32.3	22.4	0	111	87	0	36	35	35	
2025	11	28	22	38	1	25.7	-3.8	1.052	0.4	0.3	0	32.3	22.8	0	110	87	0	35	34	35	
2025	11	28	22	48	1	24.9	-3.6	1.052	0.4	0.3	0	32.3	21.9	0	110	86	0	35	35	35	
2025	11	28	22	58	1	24.6	-3	1.052	0.4	0.3	0	32.3	22.4	0	110	86	0	35	34	35	
2025	11	28	23	8	1	25.3	-2.2	1.052	0.3	0.2	0	31.8	22.4	0	109	86	0	35	34	35	
2025	11	28	23	18	1	24.6	-2	1.052	0.3	0.2	0	31.8	22.4	0	110	86	0	36	34	36	
2025	11	28	23	28	1	25.1	-3.2	1.052	0.4	0.3	0	31.4	22.4	0	109	86	0	36	34	35	
2025	11	28	23	38	1	25.3	-3.4	1.052	0.3	0.2	0	31.4	21.5	0	109	85	0	36	35	35	
2025	11	28	23	48	1	24.2	-3.2	1.052	0.4	0.3	0	31.4	22.4	0	109	86	0	36	34	35	
2025	11	28	23	58	1	24.7	-2.9	1.052	0.3	0.2	0	31.8	21.9	0	109	85	0	35	34	35	

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	29	0	8	1	26.8	-3.7	1.052	0.5	0.4	0	31.8	21.9	0	109	85	0	35	34	35
2025	11	29	0	18	1	24.8	-3.7	1.052	0.4	0.3	0	31.4	21.9	0	109	85	0	36	34	36
2025	11	29	0	28	1	25.5	-3.5	1.052	0.4	0.3	0	31.8	21.5	0	109	85	0	35	35	36
2025	11	29	0	38	1	24.9	-4.1	1.052	0.5	0.4	0	31.8	21.5	0	109	85	0	35	35	36
2025	11	29	0	48	1	24.1	-4.1	1.052	0.4	0.3	0	31.8	21.9	0	109	86	0	35	35	36
2025	11	29	0	58	1	25.1	-3.6	1.052	0.5	0.4	0	31.4	21.5	0	109	85	0	36	35	36
2025	11	29	1	8	1	24.3	-3.5	1.052	0.3	0.2	0	31.4	21.5	0	109	85	0	36	35	36
2025	11	29	1	18	1	25.5	-3.2	1.052	0.5	0.4	0	31.8	21.9	0	109	85	0	35	34	36
2025	11	29	1	28	1	24.4	-3.7	1.052	0.4	0.3	0	32.3	21.9	0	110	86	0	35	35	35
2025	11	29	1	38	1	24.6	-3.3	1.052	0.3	0.2	0	31.4	22.4	0	109	86	0	36	34	36
2025	11	29	1	48	1	25.2	-3	1.052	0.5	0.4	0	32.3	21.9	0	110	86	0	35	35	36
2025	11	29	1	58	1	25.6	-3.3	1.052	0.3	0.2	0	31.4	21.9	0	109	85	0	36	34	35
2025	11	29	2	8	1	25.2	-3.6	1.052	0.3	0.2	0	31.8	22.4	0	110	86	0	36	34	36
2025	11	29	2	18	1	25.6	-3.9	1.052	0.5	0.4	0	31.8	21.9	0	110	86	0	36	35	35
2025	11	29	2	28	1	24.8	-4.1	1.052	0.3	0.2	0	31.4	21.9	0	109	85	0	36	34	35
2025	11	29	2	38	1	24.4	-4.2	1.052	0.3	0.2	0	31	21.5	0	108	85	0	36	35	35
2025	11	29	2	48	1	24.6	-2.8	1.052	0.4	0.3	0	31	21.5	0	108	85	0	36	35	35
2025	11	29	2	58	1	25.7	-3.3	1.052	0.3	0.2	0	31.4	21.9	0	108	85	0	35	34	35
2025	11	29	3	8	1	25.2	-3.3	1.052	0.3	0.2	0	31	21.5	0	108	85	0	36	35	36
2025	11	29	3	18	1	24.4	-3.3	1.052	0.5	0.4	0	31.4	21.9	0	108	85	0	35	34	35
2025	11	29	3	28	1	24.7	-2.9	1.051	0.5	0.4	0	31.4	21.5	0	108	85	0	35	35	35
2025	11	29	3	38	1	24.9	-3.3	1.052	0.4	0.3	0	30.5	21.5	0	107	85	0	36	35	35
2025	11	29	3	48	1	25.3	-4.3	1.052	0.3	0.2	0	31	21.9	0	108	85	0	36	34	36
2025	11	29	3	58	1	23.9	-4.2	1.052	0.3	0.2	0	31.4	21.9	0	108	85	0	35	34	35
2025	11	29	4	8	1	24	-4	1.052	0.4	0.3	0	31	21.9	0	108	85	0	36	34	35
2025	11	29	4	18	1	25.3	-3.2	1.051	0.4	0.3	0	31.4	21.9	0	108	85	0	35	34	35
2025	11	29	4	28	1	23.9	-4.2	1.052	0.3	0.2	0	31.4	21.5	0	108	85	0	35	35	35
2025	11	29	4	38	1	25.1	-4.3	1.052	0.3	0.2	0	31.4	21.1	0	108	84	0	35	35	36
2025	11	29	4	48	1	24.4	-4.1	1.051	0.4	0.3	0	31.4	21.9	0	108	85	0	35	34	35
2025	11	29	4	58	1	25.1	-4.1	1.052	0.3	0.2	0	31.8	21.5	0	109	85	0	35	35	35
2025	11	29	5	8	1	23.9	-2.4	1.052	0.3	0.2	0	31.4	21.5	0	109	85	0	36	35	36
2025	11	29	5	18	1	24.7	-4	1.052	0.4	0.3	0	31.4	21.5	0	109	85	0	36	35	35
2025	11	29	5	28	1	24.4	-3.5	1.051	0.4	0.3	0	31.8	21.9	0	109	85	0	35	34	35
2025	11	29	5	38	1	25.2	-3.8	1.051	0.4	0.3	0	31.4	21.9	0	109	85	0	36	34	35
2025	11	29	5	48	1	24	-3.7	1.052	0.3	0.2	0	31	21.5	0	108	85	0	36	35	36
2025	11	29	5	58	1	25.5	-3.2	1.051	0.4	0.3	0	31	21.9	0	108	85	0	36	34	35
2025	11	29	6	8	1	24.5	-3.4	1.051	0.4	0.3	0	31	21.5	0	108	85	0	36	35	35
2025	11	29	6	18	1	25.2	-3.7	1.052	0.3	0.2	0	31	21.9	0	108	85	0	36	34	35
2025	11	29	6	28	1	25.6	-3.7	1.051	0.4	0.3	0	31.8	21.5	0	109	85	0	35	35	35
2025	11	29	6	38	1	23.8	-3.2	1.052	0.3	0.2	0	31.8	21.1	0	109	84	0	35	35	36
2025	11	29	6	48	1	25.1	-3.8	1.052	0.5	0.4	0	31.4	21.9	0	108	85	0	35	34	35
2025	11	29	6	58	1	24.1	-2.7	1.051	0.3	0.2	0	31.4	21.5	0	108	85	0	35	35	35
2025	11	29	7	8	1	23.9	-3.2	1.052	0.4	0.3	0	31	21.5	0	108	85	0	36	35	36
2025	11	29	7	18	1	24.6	-3.3	1.052	0.3	0.2	0	31	21.5	0	108	85	0	36	35	35
2025	11	29	7	28	1	23.6	-3.2	1.052	0.4	0.3	0	31.8	21.9	0	109	86	0	35	35	36
2025	11	29	7	38	1	23.8	-3	1.052	0.3	0.2	0	31.4	22.4	0	109	87	0	36	35	35
2025	11	29	7	48	1	24	-3.2	1.052	0.3	0.2	0	31.8	23.2	0	110	88	0	36	34	34
2025	11	29	7	58	1	25.2	-3.5	1.052	0.5	0.4	0	31.8	22.8	0	109	87	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	29	8	8	1	24	-2.8	1.052	0.4	0.3	0	31.4	22.4	0	109	86	0	36	34	36
2025	11	29	8	18	1	25.2	-3	1.052	0.4	0.3	0	31.4	22.8	0	109	87	0	36	34	35
2025	11	29	8	28	1	24.7	-2.1	1.051	0.3	0.2	0	31.4	22.8	0	109	87	0	36	34	35
2025	11	29	8	38	1	24.4	-3.3	1.052	0.3	0.2	0	31.4	22.8	0	109	87	0	36	34	35
2025	11	29	8	48	1	23.8	-4.4	1.051	0.3	0.2	0	31.8	22.8	0	110	87	0	36	34	35
2025	11	29	8	58	1	24.7	-4.2	1.051	0.4	0.3	0	31.8	22.8	0	109	87	0	35	34	35
2025	11	29	9	8	1	25.2	-4.3	1.052	0.5	0.5	0	31.4	22.8	0	109	87	0	36	34	35
2025	11	29	9	18	1	24.8	-3.7	1.052	0.4	0.3	0	31.8	22.8	0	109	88	0	35	35	35
2025	11	29	9	28	1	25.2	-3.9	1.052	0.3	0.2	0	31.8	21.9	0	109	86	0	35	35	36
2025	11	29	9	38	1	24.7	-3.5	1.052	0.5	0.4	0	31	22.4	0	108	86	0	36	34	36
2025	11	29	9	48	1	22.9	-3.6	1.051	0.3	0.2	0	31.4	21.5	0	108	85	0	35	35	35
2025	11	29	9	58	1	23.7	-3.9	1.051	0.5	0.4	0	31	21.5	0	108	84	0	36	34	36
2025	11	29	10	8	1	24.4	-4	1.052	0.4	0.3	0	30.5	21.1	0	107	84	0	36	35	35
2025	11	29	10	18	1	24.6	-3.3	1.051	0.4	0.3	0	30.5	21.5	0	107	84	0	36	34	35
2025	11	29	10	28	1	25.4	-3	1.052	0.4	0.3	0	31	21.1	0	107	84	0	35	35	35
2025	11	29	10	38	1	23.5	-3.5	1.051	0.3	0.2	0	31	21.1	0	107	84	0	35	35	35
2025	11	29	10	48	1	24.1	-3.5	1.052	0.4	0.3	0	30.5	21.5	0	107	84	0	36	34	35
2025	11	29	10	58	1	23.5	-4	1.052	0.3	0.2	0	30.5	21.5	0	107	84	0	36	34	35
2025	11	29	11	8	1	23.3	-3.6	1.052	0.4	0.3	0	31.4	21.5	0	108	84	0	35	34	35
2025	11	29	11	18	1	24.8	-2.8	1.052	0.3	0.2	0	30.5	21.1	0	107	84	0	36	35	35
2025	11	29	11	28	1	24	-3.6	1.052	0.4	0.3	0	32.3	22.8	0	111	87	0	36	34	35
2025	11	29	11	38	1	24.7	-3.2	1.052	0.3	0.2	0	31.4	21.5	0	108	85	0	35	35	35
2025	11	29	11	48	1	24.3	-3	1.052	0.3	0.2	0	30.5	21.1	0	107	84	0	36	35	35
2025	11	29	11	58	1	24.1	-4.1	1.052	0.3	0.2	0	30.1	21.1	0	106	83	0	36	34	35
2025	11	29	12	8	1	23.3	-2.8	1.052	0.3	0.2	0	31	21.1	0	107	84	0	35	35	35
2025	11	29	12	18	1	25.1	-3.2	1.052	0.5	0.4	0	30.1	21.5	0	106	84	0	36	34	35
2025	11	29	12	28	1	23.5	-3	1.052	0.3	0.2	0	31.4	22.4	0	108	86	0	35	34	35
2025	11	29	12	38	1	24.1	-3.7	1.052	0.4	0.3	0	31	22.4	0	108	86	0	36	34	36
2025	11	29	12	48	1	24.1	-3.7	1.052	0.3	0.2	0	31.4	21.9	0	108	86	0	35	35	36
2025	11	29	12	58	1	24.6	-3.8	1.052	0.4	0.3	0	31	22.4	0	108	86	0	36	34	35
2025	11	29	13	8	1	25.3	-3.5	1.052	0.3	0.2	0	31.4	22.4	0	108	86	0	35	34	35
2025	11	29	13	18	1	24.3	-2.5	1.052	0.4	0.3	0	31.4	22.8	0	108	87	0	35	34	36
2025	11	29	13	28	1	24.8	-2.7	1.052	0.3	0.2	0	31.4	21.9	0	108	86	0	35	35	36
2025	11	29	13	38	1	24.2	-2.5	1.052	0.3	0.2	0	31	22.4	0	108	87	0	36	35	35
2025	11	29	13	48	1	23.9	-2.7	1.052	0.5	0.4	0	31.4	22.4	0	109	87	0	36	35	35
2025	11	29	13	58	1	23.8	-2.4	1.052	0.3	0.2	0	31.8	22.4	0	109	87	0	35	35	35
2025	11	29	14	8	1	23.4	-2.6	1.053	0.3	0.2	0	31.4	22.8	0	109	88	0	36	35	35
2025	11	29	14	18	1	22.8	-3.1	1.053	0.5	0.4	0	31.8	23.2	0	110	88	0	36	34	35
2025	11	29	14	28	1	24	-2.5	1.053	0.5	0.4	0	31.8	22.4	0	109	87	0	35	35	35
2025	11	29	14	38	1	24.3	-2	1.053	0.4	0.3	0	31.8	22.8	0	109	88	0	35	35	35
2025	11	29	14	48	1	24.2	-3.3	1.052	0.4	0.3	0	31.4	22.8	0	109	88	0	36	35	35
2025	11	29	14	58	1	23.3	-2.8	1.053	0.4	0.3	0	31.4	23.2	0	109	88	0	36	34	35
2025	11	29	15	8	1	24.6	-2	1.053	0.4	0.3	0	31.8	23.2	0	109	89	0	35	35	34
2025	11	29	15	18	1	23.8	-2.6	1.053	0.4	0.3	0	31.8	23.2	0	110	89	0	36	35	35
2025	11	29	15	28	1	23.8	-2.1	1.053	0.4	0.3	0	31.8	23.6	0	109	89	0	35	34	35
2025	11	29	15	38	1	24.5	-2.7	1.053	0.5	0.5	0	31.4	22.4	0	108	87	0	35	35	35
2025	11	29	15	48	1	24.1	-2.1	1.053	0.3	0.2	0	31.4	22.4	0	108	87	0	35	35	34
2025	11	29	15	58	1	24.9	-2.8	1.053	0.3	0.2	0	31.4	22.8	0	108	87	0	35	34	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	29	16	8	1	24.1	-4.3	1.053	0.5	0.4	0	31	22.4	0	107	86	0	35	34	35
2025	11	29	16	18	1	25.7	-2.8	1.053	0.4	0.3	0	31.4	21.9	0	108	86	0	35	35	35
2025	11	29	16	28	1	23.4	-3.7	1.053	0.3	0.2	0	31.4	21.9	0	108	86	0	35	35	35
2025	11	29	16	38	1	24.6	-3	1.053	0.3	0.2	0	31	21.9	0	108	86	0	36	35	36
2025	11	29	16	48	1	24.9	-2.8	1.053	0.4	0.3	0	31.4	21.9	0	108	86	0	35	35	36
2025	11	29	16	58	1	25.2	-3.1	1.053	0.4	0.3	0	31	22.4	0	108	86	0	36	34	36
2025	11	29	17	8	1	24.5	-3.2	1.053	0.4	0.3	0	31	22.4	0	108	86	0	36	34	34
2025	11	29	17	18	1	24.2	-2.4	1.053	0.3	0.2	0	31	23.2	0	108	87	0	36	33	35
2025	11	29	17	28	1	23.1	-1.6	1.053	0.3	0.2	0	31	22.4	0	108	86	0	36	34	35
2025	11	29	17	38	1	25.4	-1.5	1.053	0.4	0.3	0	31	21.9	0	108	86	0	36	35	35
2025	11	29	17	48	1	22.7	-2.2	1.053	0.3	0.2	0	31	21.9	0	108	86	0	36	35	35
2025	11	29	17	58	1	24.1	-1.6	1.053	0.4	0.3	0	31.4	22.4	0	108	86	0	35	34	35
2025	11	29	18	8	1	24.2	-3.2	1.053	0.4	0.3	0	31	22.4	0	108	86	0	36	34	36
2025	11	29	18	18	1	24.4	-2.1	1.053	0.4	0.3	0	31.4	22.4	0	108	87	0	35	35	36
2025	11	29	18	28	1	24.5	-2.7	1.053	0.4	0.3	0	31	22.4	0	108	87	0	36	35	35
2025	11	29	18	38	1	24.4	-2.3	1.053	0.4	0.3	0	31.4	22.8	0	109	87	0	36	34	35
2025	11	29	18	48	1	24.1	-2.4	1.052	0.3	0.2	0	31	22.4	0	108	87	0	36	35	35
2025	11	29	18	58	1	24.4	-2.9	1.052	0.3	0.2	0	31.4	23.2	0	109	88	0	36	34	36
2025	11	29	19	8	1	24.9	-2	1.053	0.5	0.4	0	31.4	23.2	0	108	88	0	35	34	36
2025	11	29	19	18	1	24.4	-2.1	1.052	0.3	0.2	0	31.4	23.2	0	109	88	0	36	34	35
2025	11	29	19	28	1	23.8	-2.7	1.053	0.3	0.2	0	31.4	22.8	0	109	87	0	36	34	35
2025	11	29	19	38	1	23.9	-1.3	1.053	0.4	0.3	0	31.4	22.8	0	109	87	0	36	34	35
2025	11	29	19	48	1	22.8	-2.9	1.052	0.4	0.3	0	31.8	23.2	0	110	88	0	36	34	35
2025	11	29	19	58	1	25.9	-3	1.052	0.3	0.2	0	32.3	22.8	0	110	88	0	35	35	35
2025	11	29	20	8	1	24.5	-2.8	1.052	0.4	0.3	0	32.3	22.8	0	110	88	0	35	35	35
2025	11	29	20	18	1	24.6	-3.5	1.052	0.4	0.3	0	31.4	22.4	0	109	87	0	36	35	35
2025	11	29	20	28	1	24.9	-3	1.052	0.4	0.3	0	31.8	23.2	0	110	88	0	36	34	35
2025	11	29	20	38	1	24.3	-2.5	1.052	0.3	0.2	0	32.7	23.6	0	111	89	0	35	34	36
2025	11	29	20	48	1	24	-2.7	1.052	0.4	0.3	0	31.8	23.2	0	110	88	0	36	34	35
2025	11	29	20	58	1	24	-3	1.052	0.3	0.2	0	31.8	22.8	0	109	87	0	35	34	35
2025	11	29	21	8	1	25	-2.8	1.052	0.4	0.3	0	31.8	22.8	0	109	87	0	35	34	35
2025	11	29	21	18	1	24.9	-2.8	1.052	0.4	0.3	0	31.8	22.4	0	109	87	0	35	35	36
2025	11	29	21	28	1	25.3	-2.4	1.052	0.4	0.3	0	31.8	22.8	0	109	87	0	35	34	35
2025	11	29	21	38	1	24.5	-3.9	1.052	0.3	0.2	0	31.8	22.4	0	109	87	0	35	35	35
2025	11	29	21	48	1	23.7	-4.5	1.052	0.4	0.3	0	31	22.4	0	109	86	0	37	34	35
2025	11	29	21	58	1	25.6	-3	1.052	0.3	0.2	0	31.4	22.4	0	108	87	0	35	35	35
2025	11	29	22	8	1	24.5	-2.8	1.052	0.4	0.3	0	31	22.4	0	108	86	0	36	34	35
2025	11	29	22	18	1	23.6	-3.4	1.052	0.3	0.2	0	31	22.4	0	108	86	0	36	34	35
2025	11	29	22	28	1	25.1	-3.9	1.052	0.3	0.2	0	31.8	23.6	0	110	89	0	36	34	35
2025	11	29	22	38	1	24.4	-3.7	1.052	0.5	0.5	0	31.4	22.8	0	109	88	0	36	35	35
2025	11	29	22	48	1	24.7	-3.7	1.052	0.3	0.2	0	31.4	22.8	0	109	87	0	36	34	35
2025	11	29	22	58	1	23.5	-3	1.052	0.4	0.3	0	31.4	22.8	0	109	87	0	36	34	35
2025	11	29	23	8	1	24.3	-3.5	1.052	0.4	0.3	0	31	22.4	0	108	87	0	36	35	35
2025	11	29	23	18	1	25.6	-2.8	1.052	0.5	0.4	0	31	21.9	0	108	86	0	36	35	35
2025	11	29	23	28	1	24	-3.4	1.052	0.3	0.2	0	30.5	21.9	0	107	86	0	36	35	35
2025	11	29	23	38	1	24.1	-3.6	1.052	0.4	0.3	0	30.5	21.9	0	107	86	0	36	35	35
2025	11	29	23	48	1	25.2	-2.5	1.052	0.3	0.2	0	31.4	22.4	0	108	87	0	35	35	36
2025	11	29	23	58	1	24.2	-2.3	1.052	0.4	0.3	0	31.4	22.4	0	108	87	0	35	35	36

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	30	0	8	1	24.5	-2.6	1.051	0.4	0.3	0	31.4	22.4	0	108	87	0	35	35	35
2025	11	30	0	18	1	23.5	-2.4	1.052	0.3	0.2	0	31.4	22.4	0	108	86	0	35	34	35
2025	11	30	0	28	1	23.5	-2.2	1.052	0.4	0.3	0	31	22.4	0	108	86	0	36	34	35
2025	11	30	0	38	1	23.6	-2	1.052	0.4	0.3	0	31	22.4	0	108	86	0	36	34	35
2025	11	30	0	48	1	24.2	-2.9	1.051	0.4	0.3	0	31	22.4	0	107	86	0	35	34	35
2025	11	30	0	58	1	24	-2.4	1.052	0.5	0.4	0	31	21.9	0	108	86	0	36	35	35
2025	11	30	1	8	1	24.3	-2.7	1.051	0.3	0.2	0	30.5	21.9	0	107	86	0	36	35	35
2025	11	30	1	18	1	23.9	-2.5	1.051	0.3	0.2	0	31	22.4	0	107	86	0	35	34	36
2025	11	30	1	28	1	24.1	-2.4	1.051	0.3	0.2	0	30.5	21.9	0	107	86	0	36	35	35
2025	11	30	1	38	1	25.1	-2.4	1.051	0.3	0.2	0	31	22.4	0	107	86	0	35	34	35
2025	11	30	1	48	1	24.7	-1.1	1.051	0.3	0.2	0	30.5	22.4	0	107	86	0	36	34	35
2025	11	30	1	58	1	24.1	-3	1.051	0.4	0.3	0	30.5	21.9	0	107	86	0	36	35	35
2025	11	30	2	8	1	23.5	-1.4	1.051	0.4	0.3	0	30.5	21.9	0	107	86	0	36	35	35
2025	11	30	2	18	1	23.6	-2.4	1.051	0.4	0.3	0	31	22.4	0	108	87	0	36	35	36
2025	11	30	2	28	1	23.9	-2.6	1.051	0.5	0.4	0	31.4	22.4	0	109	87	0	36	35	36
2025	11	30	2	38	1	24.3	-2.4	1.051	0.4	0.3	0	30.5	22.4	0	107	86	0	36	34	35
2025	11	30	2	48	1	23.9	-2.2	1.051	0.3	0.2	0	30.5	22.4	0	107	86	0	36	34	35
2025	11	30	2	58	1	23.9	-3.4	1.051	0.3	0.2	0	30.5	21.9	0	107	85	0	36	34	35
2025	11	30	3	8	1	24.7	-3	1.051	0.4	0.3	0	30.5	22.4	0	107	86	0	36	34	35
2025	11	30	3	18	1	24	-3.5	1.051	0.4	0.3	0	30.1	21.9	0	106	86	0	36	35	35
2025	11	30	3	28	1	23.3	-2.2	1.051	0.3	0.2	0	30.5	21.9	0	107	86	0	36	35	36
2025	11	30	3	38	1	22.8	-2.2	1.052	0.3	0.2	0	31	22.4	0	107	86	0	35	34	35
2025	11	30	3	48	1	23	-2.8	1.051	0.4	0.3	0	30.5	21.9	0	106	85	0	35	34	35
2025	11	30	3	58	1	24.1	-3.5	1.051	0.3	0.2	0	30.5	21.5	0	107	85	0	36	35	35
2025	11	30	4	8	1	22.6	-2.4	1.051	0.4	0.3	0	30.1	21.9	0	106	86	0	36	35	36
2025	11	30	4	18	1	24.8	-3.1	1.051	0.5	0.4	0	30.5	22.4	0	107	86	0	36	34	35
2025	11	30	4	28	1	23.3	-3.2	1.052	0.5	0.5	0	30.5	21.9	0	107	86	0	36	35	36
2025	11	30	4	38	1	23.6	-2.8	1.051	0.3	0.2	0	31.8	23.2	0	110	89	0	36	35	35
2025	11	30	4	48	1	24	-2.3	1.052	0.4	0.3	0	32.7	24.1	0	112	91	0	36	35	36
2025	11	30	4	58	1	24.1	-2.7	1.051	0.4	0.3	0	37	28	0	122	99	0	36	34	35
2025	11	30	5	8	1	23	-2.4	1.051	0.3	0.2	0	34.4	25.4	0	115	94	0	35	35	35
2025	11	30	5	18	1	23.9	-2.6	1.052	0.4	0.3	0	37	27.5	0	121	99	0	35	35	36
2025	11	30	5	28	1	22.7	-2	1.051	0.4	0.3	0	34	24.9	0	115	93	0	36	35	36
2025	11	30	5	38	1	23.3	-2.4	1.052	0.5	0.4	0	33.5	25.4	0	114	93	0	36	34	35
2025	11	30	5	48	1	24.9	-2.7	1.052	0.4	0.3	0	33.5	24.5	0	114	92	0	36	35	35
2025	11	30	5	58	1	24.1	-2.4	1.052	0.3	0.2	0	32.7	24.5	0	112	91	0	36	34	36
2025	11	30	6	8	1	23.4	-3.1	1.052	0.4	0.3	0	34.8	25.8	0	116	95	0	35	35	35
2025	11	30	6	18	1	24.2	-3.3	1.052	0.4	0.3	0	39.6	30.5	0	128	106	0	36	35	35
2025	11	30	6	28	1	23.7	-2.8	1.052	0.4	0.3	0	34.4	25.4	0	116	94	0	36	35	35
2025	11	30	6	38	1	23.3	-3	1.052	0.4	0.3	0	34.4	24.9	0	115	93	0	35	35	35
2025	11	30	6	48	1	23	-3	1.052	0.3	0.2	0	33.1	23.6	0	112	90	0	35	35	36
2025	11	30	6	58	1	22.7	-3.6	1.052	0.4	0.3	0	31.4	23.2	0	109	88	0	36	34	35
2025	11	30	7	8	1	23	-3.5	1.052	0.4	0.3	0	31.8	23.6	0	110	89	0	36	34	35
2025	11	30	7	18	1	22.4	-2.1	1.052	0.4	0.3	0	31.8	22.8	0	109	88	0	35	35	36
2025	11	30	7	28	1	22.5	-2.2	1.052	0.3	0.2	0	31	22.8	0	108	88	0	36	35	34
2025	11	30	7	38	1	23.9	-3.2	1.052	0.5	0.5	0	31	22.4	0	108	87	0	36	35	35
2025	11	30	7	48	1	23.7	-3.2	1.052	0.5	0.5	0	31	22.4	0	108	87	0	36	35	35
2025	11	30	7	58	1	24	-3.1	1.052	0.4	0.3	0	31.8	22.4	0	109	87	0	35	35	36

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	30	8	8	1	23.7	-3.2	1.052	0.5	0.4	0	31.4	22.8	0	108	87	0	35	34	36
2025	11	30	8	18	1	23.9	-2.8	1.052	0.3	0.2	0	31	22.4	0	108	87	0	36	35	36
2025	11	30	8	28	1	23.9	-2.7	1.052	0.4	0.3	0	31	22.4	0	108	87	0	36	35	35
2025	11	30	8	38	1	24.2	-2.4	1.052	0.4	0.3	0	30.5	22.4	0	107	86	0	36	34	35
2025	11	30	8	48	1	23	-2	1.052	0.4	0.3	0	31	22.4	0	108	87	0	36	35	35
2025	11	30	8	58	1	23	-2.9	1.052	0.3	0.2	0	30.5	22.4	0	107	87	0	36	35	35
2025	11	30	9	8	1	21.8	-3	1.052	0.4	0.3	0	30.5	21.9	0	107	86	0	36	35	35
2025	11	30	9	18	1	23.5	-3.2	1.052	0.4	0.3	0	30.1	21.9	0	106	86	0	36	35	35
2025	11	30	9	28	1	23.1	-2.2	1.052	0.5	0.4	0	30.5	22.8	0	107	87	0	36	34	35
2025	11	30	9	38	1	22.3	-2.3	1.052	0.3	0.2	0	30.5	22.4	0	107	87	0	36	35	35
2025	11	30	9	48	1	23.4	-2.1	1.052	0.4	0.3	0	31	22.8	0	108	87	0	36	34	36
2025	11	30	9	58	1	24	-1.6	1.052	0.4	0.3	0	30.5	22.4	0	107	87	0	36	35	36
2025	11	30	10	8	1	23.4	-2	1.052	0.4	0.3	0	30.1	22.4	0	106	86	0	36	34	36
2025	11	30	10	18	1	22.7	-3.2	1.052	0.4	0.3	0	31.4	22.8	0	108	88	0	35	35	36
2025	11	30	10	28	1	22.9	-4	1.052	0.4	0.3	0	31	22.8	0	108	88	0	36	35	35
2025	11	30	10	38	1	24.3	-4.1	1.052	0.4	0.3	0	30.5	22.4	0	107	87	0	36	35	35
2025	11	30	10	48	1	23.8	-3.2	1.052	0.4	0.3	0	32.7	23.6	0	111	90	0	35	35	35
2025	11	30	10	58	1	23.7	-3.9	1.052	0.4	0.3	0	32.3	23.6	0	111	89	0	36	34	36
2025	11	30	11	8	1	23.5	-3.2	1.052	0.4	0.3	0	31.8	23.6	0	109	89	0	35	34	35
2025	11	30	11	18	1	23.1	-3.7	1.052	0.3	0.2	0	31.4	22.8	0	109	88	0	36	35	35
2025	11	30	11	28	1	23.4	-3.2	1.052	0.3	0.2	0	31.8	23.6	0	110	89	0	36	34	35
2025	11	30	11	38	1	24.9	-2.5	1.052	0.3	0.2	0	32.3	23.2	0	110	89	0	35	35	35
2025	11	30	11	48	1	24	-3.5	1.052	0.4	0.3	0	33.5	25.4	0	113	93	0	35	34	36
2025	11	30	11	58	1	23.4	-2.9	1.052	0.4	0.3	0	32.3	23.6	0	111	90	0	36	35	36
2025	11	30	12	8	1	22.8	-2	1.052	0.4	0.3	0	32.3	23.6	0	110	90	0	35	35	36
2025	11	30	12	18	1	24	-2.6	1.052	0.3	0.2	0	31	22.8	0	109	88	0	37	35	35
2025	11	30	12	28	1	24.7	-3.4	1.052	0.4	0.3	0	32.3	23.2	0	110	89	0	35	35	35
2025	11	30	12	38	1	24.2	-2.8	1.052	0.3	0.2	0	31.4	23.6	0	109	89	0	36	34	35
2025	11	30	12	48	1	24.1	-3.1	1.052	0.4	0.3	0	31.4	23.6	0	109	89	0	36	34	35
2025	11	30	12	58	1	24.1	-3.1	1.052	0.3	0.2	0	31.8	24.1	0	110	90	0	36	34	35
2025	11	30	13	8	1	23.2	-3.3	1.052	0.4	0.3	0	31.8	23.2	0	109	88	0	35	34	36
2025	11	30	13	18	1	24	-3.3	1.052	0.3	0.2	0	31	22.8	0	108	87	0	36	34	36
2025	11	30	13	28	1	23.4	-3.4	1.052	0.3	0.2	0	30.5	22.8	0	107	88	0	36	35	35
2025	11	30	13	38	1	25.2	-3.2	1.052	0.5	0.5	0	31	22.8	0	108	88	0	36	35	35
2025	11	30	13	48	1	23.6	-1.7	1.052	0.3	0.2	0	31.4	23.6	0	109	89	0	36	34	36
2025	11	30	13	58	1	25.3	-3.4	1.052	0.4	0.3	0	31.4	23.2	0	109	89	0	36	35	36
2025	11	30	14	8	1	23.9	-3.7	1.052	0.3	0.2	0	31.4	22.8	0	109	88	0	36	35	35
2025	11	30	14	18	1	24.4	-2.9	1.052	0.5	0.4	0	31	22.8	0	108	87	0	36	34	35
2025	11	30	14	28	1	22.7	-3.2	1.052	0.4	0.3	0	31	22.4	0	108	87	0	36	35	36
2025	11	30	14	38	1	24.1	-1.8	1.052	0.4	0.3	0	31	22.8	0	107	87	0	35	34	36
2025	11	30	14	48	1	23.7	-2.3	1.052	0.3	0.2	0	31	22.8	0	107	87	0	35	34	35
2025	11	30	14	58	1	24.8	-3	1.052	0.3	0.2	0	30.5	22.4	0	107	87	0	36	35	35
2025	11	30	15	8	1	23	-2	1.052	0.4	0.3	0	31	22.4	0	107	87	0	35	35	35
2025	11	30	15	18	1	23.5	-2.8	1.052	0.5	0.4	0	31	22.4	0	107	87	0	35	35	35
2025	11	30	15	28	1	24	-2.8	1.052	0.3	0.2	0	30.5	22.4	0	107	87	0	36	35	36
2025	11	30	15	38	1	24	-4.1	1.052	0.3	0.2	0	30.5	22.8	0	107	87	0	36	34	35
2025	11	30	15	48	1	22.8	-2.3	1.052	0.4	0.3	0	30.1	22.8	0	106	87	0	36	34	35
2025	11	30	15	58	1	23.7	-3.2	1.052	0.3	0.2	0	31	21.9	0	107	86	0	35	35	35

Reinhackle (0365)																				
Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	Noise3
2025	11	30	16	8	1	23.7	-4.5	1.052	0.4	0.3	0	30.1	22.4	0	106	87	0	36	35	35
2025	11	30	16	18	1	24.3	-2.7	1.052	0.4	0.3	0	30.5	22.4	0	106	87	0	35	35	35
2025	11	30	16	28	1	24.4	-3	1.052	0.3	0.2	0	30.5	21.9	0	106	86	0	35	35	35
2025	11	30	16	38	1	23.9	-2.6	1.052	0.5	0.4	0	30.1	22.4	0	106	86	0	36	34	35
2025	11	30	16	48	1	23.4	-2.4	1.052	0.4	0.3	0	30.5	22.4	0	106	86	0	35	34	35
2025	11	30	16	58	1	24.1	-2.5	1.052	0.3	0.2	0	30.1	21.9	0	106	86	0	36	35	36
2025	11	30	17	8	1	24.1	-2	1.052	0.3	0.2	0	30.1	22.4	0	106	86	0	36	34	35
2025	11	30	17	18	1	22.4	-2.2	1.052	0.3	0.2	0	30.5	21.9	0	107	86	0	36	35	36
2025	11	30	17	28	1	21.6	-2.9	1.052	0.3	0.2	0	30.5	22.4	0	107	86	0	36	34	35
2025	11	30	17	38	1	22.8	-2.8	1.052	0.4	0.3	0	30.5	22.4	0	107	86	0	36	34	36
2025	11	30	17	48	1	23	-2.2	1.052	0.3	0.2	0	31	22.4	0	107	86	0	35	34	35
2025	11	30	17	58	1	23.1	-2.9	1.052	0.3	0.2	0	30.5	21.9	0	107	86	0	36	35	35
2025	11	30	18	8	1	23.6	-2	1.052	0.5	0.4	0	30.5	22.4	0	107	87	0	36	35	36
2025	11	30	18	18	1	23.3	-1.7	1.052	0.4	0.3	0	31	22.8	0	107	87	0	35	34	35
2025	11	30	18	28	1	23.3	-1.9	1.052	0.3	0.2	0	30.5	22.8	0	107	87	0	36	34	36
2025	11	30	18	38	1	23	-1.2	1.052	0.3	0.2	0	30.5	22.8	0	107	87	0	36	34	35
2025	11	30	18	48	1	22.5	-1.7	1.052	0.4	0.3	0	30.5	22.4	0	107	87	0	36	35	35
2025	11	30	18	58	1	24	-2.6	1.052	0.3	0.2	0	31	22.4	0	107	87	0	35	35	35
2025	11	30	19	8	1	23.1	-2	1.051	0.5	0.4	0	30.5	22.4	0	107	87	0	36	35	35
2025	11	30	19	18	1	21.9	-2.9	1.051	0.4	0.3	0	31	22.4	0	107	87	0	35	35	35
2025	11	30	19	28	1	23.2	-2.4	1.051	0.5	0.4	0	30.5	22.8	0	107	87	0	36	34	35
2025	11	30	19	38	1	23.4	-2.9	1.051	0.4	0.3	0	30.5	21.9	0	107	86	0	36	35	35
2025	11	30	19	48	1	24.5	-2.1	1.051	0.4	0.3	0	31.4	22.4	0	108	87	0	35	35	36
2025	11	30	19	58	1	24.2	-2.1	1.051	0.3	0.2	0	30.5	22.4	0	107	87	0	36	35	35
2025	11	30	20	8	1	22.3	-1	1.051	0.3	0.2	0	31	22.4	0	108	87	0	36	35	36
2025	11	30	20	18	1	23.1	-3.2	1.051	0.4	0.3	0	31	22.4	0	108	87	0	36	35	35
2025	11	30	20	28	1	22	-2.4	1.051	0.3	0.2	0	30.5	22.4	0	107	87	0	36	35	35
2025	11	30	20	38	1	24	-2.2	1.051	0.3	0.2	0	30.5	22.4	0	107	87	0	36	35	35
2025	11	30	20	48	1	23	-2	1.051	0.3	0.2	0	30.5	22.8	0	107	87	0	36	34	35
2025	11	30	20	58	1	22.9	-2.1	1.051	0.3	0.2	0	30.5	22.8	0	107	87	0	36	34	36
2025	11	30	21	8	1	23.7	-2.8	1.051	0.3	0.2	0	30.5	21.9	0	107	86	0	36	35	35
2025	11	30	21	18	1	23.1	-1.7	1.051	0.4	0.3	0	31	21.9	0	107	86	0	35	35	36
2025	11	30	21	28	1	22.7	-1.6	1.051	0.3	0.2	0	30.5	22.4	0	107	87	0	36	35	35
2025	11	30	21	38	1	23.8	-1.9	1.051	0.4	0.3	0	30.5	21.9	0	107	86	0	36	35	35
2025	11	30	21	48	1	24.3	-2.9	1.051	0.3	0.2	0	30.1	21.9	0	106	86	0	36	35	35
2025	11	30	21	58	1	23.9	-3.2	1.051	0.4	0.3	0	30.5	21.9	0	107	86	0	36	35	36
2025	11	30	22	8	1	23.2	-2.8	1.05	0.3	0.2	0	30.1	21.9	0	106	86	0	36	35	35
2025	11	30	22	18	1	23.8	-2.4	1.05	0.3	0.2	0	31	22.8	0	108	87	0	36	34	35
2025	11	30	22	28	1	25.2	-2.5	1.05	0.4	0.3	0	31.4	23.2	0	109	88	0	36	34	35
2025	11	30	22	38	1	23.8	-3.5	1.05	0.4	0.3	0	31	21.9	0	107	86	0	35	35	35
2025	11	30	22	48	1	22.5	-2.2	1.05	0.4	0.3	0	31	21.9	0	107	86	0	35	35	35
2025	11	30	22	58	1	24.5	-2.7	1.05	0.4	0.3	0	30.1	22.4	0	106	86	0	36	34	35
2025	11	30	23	8	1	22.7	-2.8	1.05	0.3	0.2	0	30.1	21.9	0	106	86	0	36	35	35
2025	11	30	23	18	1	22.6	-1.5	1.05	0.4	0.3	0	30.1	22.4	0	106	86	0	36	34	36
2025	11	30	23	28	1	24.7	-3	1.05	0.3	0.2	0	30.1	21.9	0	106	86	0	36	35	36
2025	11	30	23	38	1	22.5	-2	1.05	0.3	0.2	0	30.5	21.9	0	106	86	0	35	35	35
2025	11	30	23	48	1	23.9	-3	1.05	0.3	0.2	0	29.7	21.5	0	105	85	0	36	35	35
2025	11	30	23	58	1	23.4	-2.5	1.05	0.3	0.2	0	29.7	22.4	0	105	86	0	36	34	35

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	1	0	2	15	0	0	0	0	0	0	0	9.68	0	0	11.6	0.1	1
2025	11	1	0	12	15	0	0	0	0	0	0	0	9.67	0	0	11.6	0.1	1
2025	11	1	0	22	15	0	0	0	0	0	0	0	9.66	0	0	11.6	0.1	1
2025	11	1	0	32	15	0	0	0	0	0	0	0	9.65	0	0	11.6	0.1	1
2025	11	1	0	42	15	0	0	0	0	0	0	0	9.64	0	0	11.6	0.1	1
2025	11	1	0	52	15	0	0	0	0	0	0	0	9.63	0	0	11.6	0.1	1
2025	11	1	1	2	15	0	0	0	0	0	0	0	9.62	0	0	11.6	0.1	1
2025	11	1	1	12	15	0	0	0	0	0	0	0	9.62	0	0	11.6	0.1	1
2025	11	1	1	22	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	1	1	32	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	1	1	42	15	0	0	0	0	0	0	0	9.6	0	0	11.4	0.1	1
2025	11	1	1	52	15	0	0	0	0	0	0	0	9.6	0	0	11.4	0.1	1
2025	11	1	2	2	15	0	0	0	0	0	0	0	9.59	0	0	11.4	0.1	1
2025	11	1	2	12	15	0	0	0	0	0	0	0	9.59	0	0	11.4	0.1	1
2025	11	1	2	22	15	0	0	0	0	0	0	0	9.59	0	0	11.4	0.1	1
2025	11	1	2	32	15	0	0	0	0	0	0	0	9.59	0	0	11.4	0.1	1
2025	11	1	2	42	15	0	0	0	0	0	0	0	9.59	0	0	11.4	0.1	1
2025	11	1	2	52	15	0	0	0	0	0	0	0	9.59	0	0	11.4	0.1	1
2025	11	1	3	2	15	0	0	0	0	0	0	0	9.59	0	0	11.4	0.1	1
2025	11	1	3	12	15	0	0	0	0	0	0	0	9.59	0	0	11.4	0.1	1
2025	11	1	3	22	15	0	0	0	0	0	0	0	9.6	0	0	11.4	0.1	1
2025	11	1	3	32	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	1	3	42	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	1	3	52	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	1	4	2	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	1	4	12	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	1	4	22	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	1	4	32	15	0	0	0	0	0	0	0	9.62	0	0	11.4	0.1	1
2025	11	1	4	42	15	0	0	0	0	0	0	0	9.62	0	0	11.4	0.1	1
2025	11	1	4	52	15	0	0	0	0	0	0	0	9.63	0	0	11.4	0.1	1
2025	11	1	5	2	15	0	0	0	0	0	0	0	9.63	0	0	11.4	0.1	1
2025	11	1	5	12	15	0	0	0	0	0	0	0	9.63	0	0	11.4	0.1	1
2025	11	1	5	22	15	0	0	0	0	0	0	0	9.63	0	0	11.4	0.1	1
2025	11	1	5	32	15	0	0	0	0	0	0	0	9.64	0	0	11.4	0.1	1
2025	11	1	5	42	15	0	0	0	0	0	0	0	9.64	0	0	11.4	0.1	1
2025	11	1	5	52	15	0	0	0	0	0	0	0	9.64	0	0	11.4	0.1	1
2025	11	1	6	2	15	0	0	0	0	0	0	0	9.64	0	0	11.4	0.1	1
2025	11	1	6	12	15	0	0	0	0	0	0	0	9.65	0	0	11.4	0.1	1
2025	11	1	6	22	15	0	0	0	0	0	0	0	9.65	0	0	11.4	0.1	1
2025	11	1	6	32	15	0	0	0	0	0	0	0	9.66	0	0	11.4	0.1	1
2025	11	1	6	42	15	0	0	0	0	0	0	0	9.66	0	0	11.4	0.1	1
2025	11	1	6	52	15	0	0	0	0	0	0	0	9.66	0	0	11.4	0.1	1
2025	11	1	7	2	15	0	0	0	0	0	0	0	9.66	0	0	11.4	0.1	1
2025	11	1	7	12	15	0	0	0	0	0	0	0	9.67	0	0	11.4	0.1	1
2025	11	1	7	22	15	0	0	0	0	0	0	0	9.67	0	0	11.4	0.1	1
2025	11	1	7	32	15	0	0	0	0	0	0	0	9.67	0	0	11.4	0.1	1
2025	11	1	7	42	15	0	0	0	0	0	0	0	9.68	0	0	11.4	0.1	1
2025	11	1	7	52	15	0	0	0	0	0	0	0	9.68	0	0	11.4	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	1	8	2	15	0	0	0	0	0	0	0	9.69	0	0	11.8	0.1	1
2025	11	1	8	12	15	0	0	0	0	0	0	0	9.69	0	0	12	0.1	1
2025	11	1	8	22	15	0	0	0	0	0	0	0	9.7	0	0	12.2	0.1	1
2025	11	1	8	32	15	0	0	0	0	0	0	0	9.72	0	0	12.4	0.1	1
2025	11	1	8	42	15	0	0	0	0	0	0	0	9.75	0	0	12.4	0.1	1
2025	11	1	8	52	15	0	0	0	0	0	0	0	9.8	0	0	12.6	0.1	1
2025	11	1	9	2	15	0	0	0	0	0	0	0	9.85	0	0	12.6	0.1	1
2025	11	1	9	12	15	0	0	0	0	0	0	0	9.9	0	0	12.2	0.1	1
2025	11	1	9	22	15	0	0	0	0	0	0	0	9.94	0	0	12.6	0.1	1
2025	11	1	9	32	15	0	0	0	0	0	0	0	9.98	0	0	12.4	0.1	1
2025	11	1	9	42	15	0	0	0	0	0	0	0	10.03	0	0	12.4	0.1	1
2025	11	1	9	52	15	0	0	0	0	0	0	0	10.06	0	0	12.4	0.1	1
2025	11	1	10	2	15	0	0	0	0	0	0	0	10.11	0	0	12.4	0.1	1
2025	11	1	10	12	15	0	0	0	0	0	0	0	10.15	0	0	12.6	0.1	1
2025	11	1	10	22	15	0	0	0	0	0	0	0	10.18	0	0	13	0.1	1
2025	11	1	10	32	15	0	0	0	0	0	0	0	10.23	0	0	13	0.1	1
2025	11	1	10	42	15	0	0	0	0	0	0	0	10.26	0	0	13	0.1	1
2025	11	1	10	52	15	0	0	0	0	0	0	0	10.3	0	0	13	0.1	1
2025	11	1	11	2	15	0	0	0	0	0	0	0	10.35	0	0	13	0.1	1
2025	11	1	11	12	15	0	0	0	0	0	0	0	10.38	0	0	13	0.1	1
2025	11	1	11	22	15	0	0	0	0	0	0	0	10.4	0	0	13	0.1	1
2025	11	1	11	32	15	0	0	0	0	0	0	0	10.43	0	0	13	0.1	1
2025	11	1	11	42	15	0	0	0	0	0	0	0	10.48	0	0	13	0.1	1
2025	11	1	11	52	15	0	0	0	0	0	0	0	10.51	0	0	12.8	0.1	1
2025	11	1	12	2	15	0	0	0	0	0	0	0	10.54	0	0	12.8	0.1	1
2025	11	1	12	12	15	0	0	0	0	0	0	0	10.57	0	0	12.8	0.1	1
2025	11	1	12	22	15	0	0	0	0	0	0	0	10.59	0	0	12.8	0.1	1
2025	11	1	12	32	15	0	0	0	0	0	0	0	10.6	0	0	12.8	0.1	1
2025	11	1	12	42	15	0	0	0	0	0	0	0	10.62	0	0	12.8	0.1	1
2025	11	1	12	52	15	0	0	0	0	0	0	0	10.63	0	0	12.8	0.1	1
2025	11	1	13	2	15	0	0	0	0	0	0	0	10.64	0	0	12.8	0.1	1
2025	11	1	13	12	15	0	0	0	0	0	0	0	10.65	0	0	12.8	0.1	1
2025	11	1	13	22	15	0	0	0	0	0	0	0	10.66	0	0	12.8	0.1	1
2025	11	1	13	32	15	0	0	0	0	0	0	0	10.66	0	0	13	0.1	1
2025	11	1	13	42	15	0	0	0	0	0	0	0	10.66	0	0	13	0.1	1
2025	11	1	13	52	15	0	0	0	0	0	0	0	10.67	0	0	12.8	0.1	1
2025	11	1	14	2	15	0	0	0	0	0	0	0	10.67	0	0	12.8	0.1	1
2025	11	1	14	12	15	0	0	0	0	0	0	0	10.67	0	0	12.8	0.1	1
2025	11	1	14	22	15	0	0	0	0	0	0	0	10.66	0	0	12.8	0.1	1
2025	11	1	14	32	15	0	0	0	0	0	0	0	10.65	0	0	12.8	0.1	1
2025	11	1	14	42	15	0	0	0	0	0	0	0	10.65	0	0	12.8	0.1	1
2025	11	1	14	52	15	0	0	0	0	0	0	0	10.62	0	0	12.8	0.1	1
2025	11	1	15	2	15	0	0	0	0	0	0	0	10.61	0	0	12.8	0.1	1
2025	11	1	15	12	15	0	0	0	0	0	0	0	10.59	0	0	12.8	0.1	1
2025	11	1	15	22	15	0	0	0	0	0	0	0	10.58	0	0	12.8	0.1	1
2025	11	1	15	32	15	0	0	0	0	0	0	0	10.56	0	0	12.8	0.1	1
2025	11	1	15	42	15	0	0	0	0	0	0	0	10.49	0	0	12.8	0.1	1
2025	11	1	15	52	15	0	0	0	0	0	0	0	10.47	0	0	12.8	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	1	16	2	15	0	0	0	0	0	0	0	10.45	0	0	12.8	0.1	1
2025	11	1	16	12	15	0	0	0	0	0	0	0	10.43	0	0	12.8	0.1	1
2025	11	1	16	22	15	0	0	0	0	0	0	0	10.41	0	0	12	0.1	1
2025	11	1	16	32	15	0	0	0	0	0	0	0	10.4	0	0	11.8	0.1	1
2025	11	1	16	42	15	0	0	0	0	0	0	0	10.39	0	0	11.6	0.1	1
2025	11	1	16	52	15	0	0	0	0	0	0	0	10.38	0	0	11.4	0.1	1
2025	11	1	17	2	15	0	0	0	0	0	0	0	10.38	0	0	11.4	0.1	1
2025	11	1	17	12	15	0	0	0	0	0	0	0	10.37	0	0	11.2	0.1	1
2025	11	1	17	22	15	0	0	0	0	0	0	0	10.36	0	0	11	0.1	1
2025	11	1	17	32	15	0	0	0	0	0	0	0	10.35	0	0	11	0.1	1
2025	11	1	17	42	15	0	0	0	0	0	0	0	10.34	0	0	11.2	0.1	1
2025	11	1	17	52	15	0	0	0	0	0	0	0	10.32	0	0	11.4	0.1	1
2025	11	1	18	2	15	0	0	0	0	0	0	0	10.31	0	0	11.6	0.1	1
2025	11	1	18	12	15	0	0	0	0	0	0	0	10.29	0	0	11.6	0.1	1
2025	11	1	18	22	15	0	0	0	0	0	0	0	10.28	0	0	11.6	0.1	1
2025	11	1	18	32	15	0	0	0	0	0	0	0	10.26	0	0	11.6	0.1	1
2025	11	1	18	42	15	0	0	0	0	0	0	0	10.24	0	0	11.6	0.1	1
2025	11	1	18	52	15	0	0	0	0	0	0	0	10.22	0	0	11.6	0.1	1
2025	11	1	19	2	15	0	0	0	0	0	0	0	10.19	0	0	11.6	0.1	1
2025	11	1	19	12	15	0	0	0	0	0	0	0	10.18	0	0	11.6	0.1	1
2025	11	1	19	22	15	0	0	0	0	0	0	0	10.15	0	0	11.6	0.1	1
2025	11	1	19	32	15	0	0	0	0	0	0	0	10.12	0	0	11.6	0.1	1
2025	11	1	19	42	15	0	0	0	0	0	0	0	10.1	0	0	11.6	0.1	1
2025	11	1	19	52	15	0	0	0	0	0	0	0	10.08	0	0	11.6	0.1	1
2025	11	1	20	2	15	0	0	0	0	0	0	0	10.06	0	0	11.6	0.1	1
2025	11	1	20	12	15	0	0	0	0	0	0	0	10.03	0	0	11.6	0.1	1
2025	11	1	20	22	15	0	0	0	0	0	0	0	10	0	0	11.6	0.1	1
2025	11	1	20	32	15	0	0	0	0	0	0	0	9.98	0	0	11.6	0.1	1
2025	11	1	20	42	15	0	0	0	0	0	0	0	9.95	0	0	11.4	0.1	1
2025	11	1	20	52	15	0	0	0	0	0	0	0	9.92	0	0	11.6	0.1	1
2025	11	1	21	2	15	0	0	0	0	0	0	0	9.9	0	0	11.6	0.1	1
2025	11	1	21	12	15	0	0	0	0	0	0	0	9.88	0	0	11.6	0.1	1
2025	11	1	21	22	15	0	0	0	0	0	0	0	9.85	0	0	11.4	0.1	1
2025	11	1	21	32	15	0	0	0	0	0	0	0	9.83	0	0	11.4	0.1	1
2025	11	1	21	42	15	0	0	0	0	0	0	0	9.8	0	0	11.6	0.1	1
2025	11	1	21	52	15	0	0	0	0	0	0	0	9.78	0	0	11.6	0.1	1
2025	11	1	22	2	15	0	0	0	0	0	0	0	9.76	0	0	11.6	0.1	1
2025	11	1	22	12	15	0	0	0	0	0	0	0	9.74	0	0	11.6	0.1	1
2025	11	1	22	22	15	0	0	0	0	0	0	0	9.71	0	0	11.6	0.1	1
2025	11	1	22	32	15	0	0	0	0	0	0	0	9.69	0	0	11.6	0.1	1
2025	11	1	22	42	15	0	0	0	0	0	0	0	9.67	0	0	11.6	0.1	1
2025	11	1	22	52	15	0	0	0	0	0	0	0	9.66	0	0	11.6	0.1	1
2025	11	1	23	2	15	0	0	0	0	0	0	0	9.63	0	0	11.6	0.1	1
2025	11	1	23	12	15	0	0	0	0	0	0	0	9.61	0	0	11.6	0.1	1
2025	11	1	23	22	15	0	0	0	0	0	0	0	9.6	0	0	11.6	0.1	1
2025	11	1	23	32	15	0	0	0	0	0	0	0	9.57	0	0	11.6	0.1	1
2025	11	1	23	42	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1
2025	11	1	23	52	15	0	0	0	0	0	0	0	9.54	0	0	11.6	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	2	0	2	15	0	0	0	0	0	0	0	9.52	0	0	11.6	0.1	1
2025	11	2	0	12	15	0	0	0	0	0	0	0	9.51	0	0	11.6	0.1	1
2025	11	2	0	22	15	0	0	0	0	0	0	0	9.5	0	0	11.6	0.1	1
2025	11	2	0	32	15	0	0	0	0	0	0	0	9.5	0	0	11.6	0.1	1
2025	11	2	0	42	15	0	0	0	0	0	0	0	9.48	0	0	11.6	0.1	1
2025	11	2	0	52	15	0	0	0	0	0	0	0	9.47	0	0	11.6	0.1	1
2025	11	2	1	2	15	0	0	0	0	0	0	0	9.47	0	0	11.6	0.1	1
2025	11	2	1	12	15	0	0	0	0	0	0	0	9.45	0	0	11.6	0.1	1
2025	11	2	1	22	15	0	0	0	0	0	0	0	9.45	0	0	11.6	0.1	1
2025	11	2	1	32	15	0	0	0	0	0	0	0	9.45	0	0	11.4	0.1	1
2025	11	2	1	42	15	0	0	0	0	0	0	0	9.44	0	0	11.4	0.1	1
2025	11	2	1	52	15	0	0	0	0	0	0	0	9.44	0	0	11.4	0.1	1
2025	11	2	2	2	15	0	0	0	0	0	0	0	9.44	0	0	11.4	0.1	1
2025	11	2	2	12	15	0	0	0	0	0	0	0	9.44	0	0	11.4	0.1	1
2025	11	2	2	22	15	0	0	0	0	0	0	0	9.44	0	0	11.4	0.1	1
2025	11	2	2	32	15	0	0	0	0	0	0	0	9.44	0	0	11.4	0.1	1
2025	11	2	2	42	15	0	0	0	0	0	0	0	9.44	0	0	11.4	0.1	1
2025	11	2	2	52	15	0	0	0	0	0	0	0	9.44	0	0	11.4	0.1	1
2025	11	2	3	2	15	0	0	0	0	0	0	0	9.44	0	0	11.4	0.1	1
2025	11	2	3	12	15	0	0	0	0	0	0	0	9.44	0	0	11.4	0.1	1
2025	11	2	3	22	15	0	0	0	0	0	0	0	9.44	0	0	11.4	0.1	1
2025	11	2	3	32	15	0	0	0	0	0	0	0	9.44	0	0	11.4	0.1	1
2025	11	2	3	42	15	0	0	0	0	0	0	0	9.44	0	0	11.4	0.1	1
2025	11	2	3	52	15	0	0	0	0	0	0	0	9.44	0	0	11.4	0.1	1
2025	11	2	4	2	15	0	0	0	0	0	0	0	9.44	0	0	11.4	0.1	1
2025	11	2	4	12	15	0	0	0	0	0	0	0	9.45	0	0	11.4	0.1	1
2025	11	2	4	22	15	0	0	0	0	0	0	0	9.45	0	0	11.4	0.1	1
2025	11	2	4	32	15	0	0	0	0	0	0	0	9.46	0	0	11.4	0.1	1
2025	11	2	4	42	15	0	0	0	0	0	0	0	9.46	0	0	11.4	0.1	1
2025	11	2	4	52	15	0	0	0	0	0	0	0	9.47	0	0	11.4	0.1	1
2025	11	2	5	2	15	0	0	0	0	0	0	0	9.47	0	0	11.4	0.1	1
2025	11	2	5	12	15	0	0	0	0	0	0	0	9.47	0	0	11.4	0.1	1
2025	11	2	5	22	15	0	0	0	0	0	0	0	9.48	0	0	11.4	0.1	1
2025	11	2	5	32	15	0	0	0	0	0	0	0	9.48	0	0	11.4	0.1	1
2025	11	2	5	42	15	0	0	0	0	0	0	0	9.49	0	0	11.4	0.1	1
2025	11	2	5	52	15	0	0	0	0	0	0	0	9.49	0	0	11.4	0.1	1
2025	11	2	6	2	15	0	0	0	0	0	0	0	9.49	0	0	11.4	0.1	1
2025	11	2	6	12	15	0	0	0	0	0	0	0	9.5	0	0	11.4	0.1	1
2025	11	2	6	22	15	0	0	0	0	0	0	0	9.5	0	0	11.4	0.1	1
2025	11	2	6	32	15	0	0	0	0	0	0	0	9.51	0	0	11.4	0.1	1
2025	11	2	6	42	15	0	0	0	0	0	0	0	9.5	0	0	11.4	0.1	1
2025	11	2	6	52	15	0	0	0	0	0	0	0	9.5	0	0	11.4	0.1	1
2025	11	2	7	2	15	0	0	0	0	0	0	0	9.51	0	0	11.4	0.1	1
2025	11	2	7	12	15	0	0	0	0	0	0	0	9.51	0	0	11.4	0.1	1
2025	11	2	7	22	15	0	0	0	0	0	0	0	9.52	0	0	11.4	0.1	1
2025	11	2	7	32	15	0	0	0	0	0	0	0	9.52	0	0	11.4	0.1	1
2025	11	2	7	42	15	0	0	0	0	0	0	0	9.52	0	0	11.4	0.1	1
2025	11	2	7	52	15	0	0	0	0	0	0	0	9.53	0	0	11.4	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	2	8	2	15	0	0	0	0	0	0	0	9.54	0	0	11.8	0.1	1
2025	11	2	8	12	15	0	0	0	0	0	0	0	9.55	0	0	12	0.1	1
2025	11	2	8	22	15	0	0	0	0	0	0	0	9.56	0	0	12.2	0.1	1
2025	11	2	8	32	15	0	0	0	0	0	0	0	9.57	0	0	12.4	0.1	1
2025	11	2	8	42	15	0	0	0	0	0	0	0	9.6	0	0	12.4	0.1	1
2025	11	2	8	52	15	0	0	0	0	0	0	0	9.65	0	0	12.6	0.1	1
2025	11	2	9	2	15	0	0	0	0	0	0	0	9.7	0	0	12.6	0.1	1
2025	11	2	9	12	15	0	0	0	0	0	0	0	9.74	0	0	12.2	0.1	1
2025	11	2	9	22	15	0	0	0	0	0	0	0	9.79	0	0	12.2	0.1	1
2025	11	2	9	32	15	0	0	0	0	0	0	0	9.83	0	0	12.2	0.1	1
2025	11	2	9	42	15	0	0	0	0	0	0	0	9.86	0	0	12.4	0.1	1
2025	11	2	9	52	15	0	0	0	0	0	0	0	9.91	0	0	12.4	0.1	1
2025	11	2	10	2	15	0	0	0	0	0	0	0	9.95	0	0	12.4	0.1	1
2025	11	2	10	12	15	0	0	0	0	0	0	0	9.99	0	0	12.6	0.1	1
2025	11	2	10	22	15	0	0	0	0	0	0	0	10.02	0	0	13.2	0.1	1
2025	11	2	10	32	15	0	0	0	0	0	0	0	10.07	0	0	13.2	0.1	1
2025	11	2	10	42	15	0	0	0	0	0	0	0	10.1	0	0	13.2	0.1	1
2025	11	2	10	52	15	0	0	0	0	0	0	0	10.12	0	0	13.2	0.1	1
2025	11	2	11	2	15	0	0	0	0	0	0	0	10.18	0	0	13.2	0.1	1
2025	11	2	11	12	15	0	0	0	0	0	0	0	10.21	0	0	13.2	0.1	1
2025	11	2	11	22	15	0	0	0	0	0	0	0	10.25	0	0	13.2	0.1	1
2025	11	2	11	32	15	0	0	0	0	0	0	0	10.25	0	0	13.2	0.1	1
2025	11	2	11	42	15	0	0	0	0	0	0	0	10.26	0	0	13	0.1	1
2025	11	2	11	52	15	0	0	0	0	0	0	0	10.33	0	0	13	0.1	1
2025	11	2	12	2	15	0	0	0	0	0	0	0	10.21	0	0	12.8	0.1	1
2025	11	2	12	12	15	0	0	0	0	0	0	0	10.34	0	0	13	0.1	1
2025	11	2	12	22	15	0	0	0	0	0	0	0	10.31	0	0	13.4	0.1	1
2025	11	2	12	32	15	0	0	0	0	0	0	0	10.19	0	0	13.2	0.1	1
2025	11	2	12	42	15	0	0	0	0	0	0	0	10.24	0	0	13.2	0.1	1
2025	11	2	12	52	15	0	0	0	0	0	0	0	10.27	0	0	13.2	0.1	1
2025	11	2	13	2	15	0	0	0	0	0	0	0	10.32	0	0	13.4	0.1	1
2025	11	2	13	12	15	0	0	0	0	0	0	0	10.3	0	0	13.2	0.1	1
2025	11	2	13	22	15	0	0	0	0	0	0	0	10.37	0	0	13.4	0.1	1
2025	11	2	13	32	15	0	0	0	0	0	0	0	10.32	0	0	13.4	0.1	1
2025	11	2	13	42	15	0	0	0	0	0	0	0	10.35	0	0	13.4	0.1	1
2025	11	2	13	52	15	0	0	0	0	0	0	0	10.31	0	0	13.2	0.1	1
2025	11	2	14	2	15	0	0	0	0	0	0	0	10.44	0	0	13.2	0.1	1
2025	11	2	14	12	15	0	0	0	0	0	0	0	10.42	0	0	13.2	0.1	1
2025	11	2	14	22	15	0	0	0	0	0	0	0	10.47	0	0	13.2	0.1	1
2025	11	2	14	32	15	0	0	0	0	0	0	0	10.47	0	0	13.2	0.1	1
2025	11	2	14	42	15	0	0	0	0	0	0	0	10.46	0	0	13.2	0.1	1
2025	11	2	14	52	15	0	0	0	0	0	0	0	10.44	0	0	13.2	0.1	1
2025	11	2	15	2	15	0	0	0	0	0	0	0	10.43	0	0	13.2	0.1	1
2025	11	2	15	12	15	0	0	0	0	0	0	0	10.41	0	0	13.2	0.1	1
2025	11	2	15	22	15	0	0	0	0	0	0	0	10.4	0	0	13.2	0.1	1
2025	11	2	15	32	15	0	0	0	0	0	0	0	10.38	0	0	13.2	0.1	1
2025	11	2	15	42	15	0	0	0	0	0	0	0	10.33	0	0	13.2	0.1	1
2025	11	2	15	52	15	0	0	0	0	0	0	0	10.27	0	0	13.2	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	2	16	2	15	0	0	0	0	0	0	0	10.24	0	0	13.2	0.1	1
2025	11	2	16	12	15	0	0	0	0	0	0	0	10.23	0	0	13.2	0.1	1
2025	11	2	16	22	15	0	0	0	0	0	0	0	10.21	0	0	12.6	0.1	1
2025	11	2	16	32	15	0	0	0	0	0	0	0	10.2	0	0	12.2	0.1	1
2025	11	2	16	42	15	0	0	0	0	0	0	0	10.2	0	0	12.2	0.1	1
2025	11	2	16	52	15	0	0	0	0	0	0	0	10.19	0	0	12	0.1	1
2025	11	2	17	2	15	0	0	0	0	0	0	0	10.19	0	0	11.8	0.1	1
2025	11	2	17	12	15	0	0	0	0	0	0	0	10.18	0	0	11.6	0.1	1
2025	11	2	17	22	15	0	0	0	0	0	0	0	10.17	0	0	11.4	0.1	1
2025	11	2	17	32	15	0	0	0	0	0	0	0	10.16	0	0	11.4	0.1	1
2025	11	2	17	42	15	0	0	0	0	0	0	0	10.15	0	0	11.4	0.1	1
2025	11	2	17	52	15	0	0	0	0	0	0	0	10.14	0	0	11.4	0.1	1
2025	11	2	18	2	15	0	0	0	0	0	0	0	10.12	0	0	11.6	0.1	1
2025	11	2	18	12	15	0	0	0	0	0	0	0	10.11	0	0	11.4	0.1	1
2025	11	2	18	22	15	0	0	0	0	0	0	0	10.1	0	0	11.4	0.1	1
2025	11	2	18	32	15	0	0	0	0	0	0	0	10.08	0	0	11.4	0.1	1
2025	11	2	18	42	15	0	0	0	0	0	0	0	10.06	0	0	11.4	0.1	1
2025	11	2	18	52	15	0	0	0	0	0	0	0	10.04	0	0	11.6	0.1	1
2025	11	2	19	2	15	0	0	0	0	0	0	0	10.01	0	0	11.8	0.1	1
2025	11	2	19	12	15	0	0	0	0	0	0	0	9.99	0	0	11.6	0.1	1
2025	11	2	19	22	15	0	0	0	0	0	0	0	9.97	0	0	11.6	0.1	1
2025	11	2	19	32	15	0	0	0	0	0	0	0	9.94	0	0	11.6	0.1	1
2025	11	2	19	42	15	0	0	0	0	0	0	0	9.91	0	0	11.6	0.1	1
2025	11	2	19	52	15	0	0	0	0	0	0	0	9.89	0	0	11.6	0.1	1
2025	11	2	20	2	15	0	0	0	0	0	0	0	9.86	0	0	11.6	0.1	1
2025	11	2	20	12	15	0	0	0	0	0	0	0	9.83	0	0	11.6	0.1	1
2025	11	2	20	22	15	0	0	0	0	0	0	0	9.81	0	0	11.6	0.1	1
2025	11	2	20	32	15	0	0	0	0	0	0	0	9.79	0	0	11.6	0.1	1
2025	11	2	20	42	15	0	0	0	0	0	0	0	9.77	0	0	11.6	0.1	1
2025	11	2	20	52	15	0	0	0	0	0	0	0	9.74	0	0	11.6	0.1	1
2025	11	2	21	2	15	0	0	0	0	0	0	0	9.72	0	0	11.6	0.1	1
2025	11	2	21	12	15	0	0	0	0	0	0	0	9.69	0	0	11.6	0.1	1
2025	11	2	21	22	15	0	0	0	0	0	0	0	9.67	0	0	11.6	0.1	1
2025	11	2	21	32	15	0	0	0	0	0	0	0	9.65	0	0	11.6	0.1	1
2025	11	2	21	42	15	0	0	0	0	0	0	0	9.63	0	0	11.6	0.1	1
2025	11	2	21	52	15	0	0	0	0	0	0	0	9.61	0	0	11.6	0.1	1
2025	11	2	22	2	15	0	0	0	0	0	0	0	9.58	0	0	11.6	0.1	1
2025	11	2	22	12	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1
2025	11	2	22	22	15	0	0	0	0	0	0	0	9.54	0	0	11.6	0.1	1
2025	11	2	22	32	15	0	0	0	0	0	0	0	9.53	0	0	11.6	0.1	1
2025	11	2	22	42	15	0	0	0	0	0	0	0	9.5	0	0	11.6	0.1	1
2025	11	2	22	52	15	0	0	0	0	0	0	0	9.49	0	0	11.6	0.1	1
2025	11	2	23	2	15	0	0	0	0	0	0	0	9.46	0	0	11.6	0.1	1
2025	11	2	23	12	15	0	0	0	0	0	0	0	9.44	0	0	11.6	0.1	1
2025	11	2	23	22	15	0	0	0	0	0	0	0	9.43	0	0	11.6	0.1	1
2025	11	2	23	32	15	0	0	0	0	0	0	0	9.41	0	0	11.6	0.1	1
2025	11	2	23	42	15	0	0	0	0	0	0	0	9.39	0	0	11.6	0.1	1
2025	11	2	23	52	15	0	0	0	0	0	0	0	9.38	0	0	11.6	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	3	0	2	15	0	0	0	0	0	0	0	9.36	0	0	11.6	0.1	1
2025	11	3	0	12	15	0	0	0	0	0	0	0	9.35	0	0	11.6	0.1	1
2025	11	3	0	22	15	0	0	0	0	0	0	0	9.34	0	0	11.6	0.1	1
2025	11	3	0	32	15	0	0	0	0	0	0	0	9.33	0	0	11.6	0.1	1
2025	11	3	0	42	15	0	0	0	0	0	0	0	9.32	0	0	11.6	0.1	1
2025	11	3	0	52	15	0	0	0	0	0	0	0	9.3	0	0	11.6	0.1	1
2025	11	3	1	2	15	0	0	0	0	0	0	0	9.3	0	0	11.6	0.1	1
2025	11	3	1	12	15	0	0	0	0	0	0	0	9.29	0	0	11.6	0.1	1
2025	11	3	1	22	15	0	0	0	0	0	0	0	9.29	0	0	11.6	0.1	1
2025	11	3	1	32	15	0	0	0	0	0	0	0	9.28	0	0	11.6	0.1	1
2025	11	3	1	42	15	0	0	0	0	0	0	0	9.27	0	0	11.6	0.1	1
2025	11	3	1	52	15	0	0	0	0	0	0	0	9.27	0	0	11.6	0.1	1
2025	11	3	2	2	15	0	0	0	0	0	0	0	9.27	0	0	11.6	0.1	1
2025	11	3	2	12	15	0	0	0	0	0	0	0	9.27	0	0	11.6	0.1	1
2025	11	3	2	22	15	0	0	0	0	0	0	0	9.26	0	0	11.6	0.1	1
2025	11	3	2	32	15	0	0	0	0	0	0	0	9.26	0	0	11.6	0.1	1
2025	11	3	2	42	15	0	0	0	0	0	0	0	9.26	0	0	11.6	0.1	1
2025	11	3	2	52	15	0	0	0	0	0	0	0	9.26	0	0	11.6	0.1	1
2025	11	3	3	2	15	0	0	0	0	0	0	0	9.26	0	0	11.6	0.1	1
2025	11	3	3	12	15	0	0	0	0	0	0	0	9.26	0	0	11.6	0.1	1
2025	11	3	3	22	15	0	0	0	0	0	0	0	9.27	0	0	11.6	0.1	1
2025	11	3	3	32	15	0	0	0	0	0	0	0	9.27	0	0	11.4	0.1	1
2025	11	3	3	42	15	0	0	0	0	0	0	0	9.27	0	0	11.4	0.1	1
2025	11	3	3	52	15	0	0	0	0	0	0	0	9.27	0	0	11.4	0.1	1
2025	11	3	4	2	15	0	0	0	0	0	0	0	9.28	0	0	11.4	0.1	1
2025	11	3	4	12	15	0	0	0	0	0	0	0	9.28	0	0	11.4	0.1	1
2025	11	3	4	22	15	0	0	0	0	0	0	0	9.28	0	0	11.4	0.1	1
2025	11	3	4	32	15	0	0	0	0	0	0	0	9.28	0	0	11.4	0.1	1
2025	11	3	4	42	15	0	0	0	0	0	0	0	9.29	0	0	11.4	0.1	1
2025	11	3	4	52	15	0	0	0	0	0	0	0	9.29	0	0	11.4	0.1	1
2025	11	3	5	2	15	0	0	0	0	0	0	0	9.29	0	0	11.4	0.1	1
2025	11	3	5	12	15	0	0	0	0	0	0	0	9.3	0	0	11.4	0.1	1
2025	11	3	5	22	15	0	0	0	0	0	0	0	9.3	0	0	11.4	0.1	1
2025	11	3	5	32	15	0	0	0	0	0	0	0	9.31	0	0	11.4	0.1	1
2025	11	3	5	42	15	0	0	0	0	0	0	0	9.31	0	0	11.4	0.1	1
2025	11	3	5	52	15	0	0	0	0	0	0	0	9.31	0	0	11.4	0.1	1
2025	11	3	6	2	15	0	0	0	0	0	0	0	9.32	0	0	11.4	0.1	1
2025	11	3	6	12	15	0	0	0	0	0	0	0	9.32	0	0	11.4	0.1	1
2025	11	3	6	22	15	0	0	0	0	0	0	0	9.33	0	0	11.4	0.1	1
2025	11	3	6	32	15	0	0	0	0	0	0	0	9.33	0	0	11.4	0.1	1
2025	11	3	6	42	15	0	0	0	0	0	0	0	9.33	0	0	11.4	0.1	1
2025	11	3	6	52	15	0	0	0	0	0	0	0	9.33	0	0	11.4	0.1	1
2025	11	3	7	2	15	0	0	0	0	0	0	0	9.34	0	0	11.4	0.1	1
2025	11	3	7	12	15	0	0	0	0	0	0	0	9.34	0	0	11.4	0.1	1
2025	11	3	7	22	15	0	0	0	0	0	0	0	9.34	0	0	11.4	0.1	1
2025	11	3	7	32	15	0	0	0	0	0	0	0	9.34	0	0	11.4	0.1	1
2025	11	3	7	42	15	0	0	0	0	0	0	0	9.34	0	0	11.4	0.1	1
2025	11	3	7	52	15	0	0	0	0	0	0	0	9.35	0	0	11.4	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	3	8	2	15	0	0	0	0	0	0	0	9.35	0	0	11.8	0.1	1
2025	11	3	8	12	15	0	0	0	0	0	0	0	9.36	0	0	12	0.1	1
2025	11	3	8	22	15	0	0	0	0	0	0	0	9.36	0	0	12.2	0.1	1
2025	11	3	8	32	15	0	0	0	0	0	0	0	9.38	0	0	12.4	0.1	1
2025	11	3	8	42	15	0	0	0	0	0	0	0	9.4	0	0	12.6	0.1	1
2025	11	3	8	52	15	0	0	0	0	0	0	0	9.45	0	0	12.6	0.1	1
2025	11	3	9	2	15	0	0	0	0	0	0	0	9.48	0	0	12.6	0.1	1
2025	11	3	9	12	15	0	0	0	0	0	0	0	9.51	0	0	12.6	0.1	1
2025	11	3	9	22	15	0	0	0	0	0	0	0	9.55	0	0	12.6	0.1	1
2025	11	3	9	32	15	0	0	0	0	0	0	0	9.6	0	0	12.8	0.1	1
2025	11	3	9	42	15	0	0	0	0	0	0	0	9.64	0	0	12.8	0.1	1
2025	11	3	9	52	15	0	0	0	0	0	0	0	9.67	0	0	12.8	0.1	1
2025	11	3	10	2	15	0	0	0	0	0	0	0	9.7	0	0	13	0.1	1
2025	11	3	10	12	15	0	0	0	0	0	0	0	9.74	0	0	13	0.1	1
2025	11	3	10	22	15	0	0	0	0	0	0	0	9.78	0	0	13.2	0.1	1
2025	11	3	10	32	15	0	0	0	0	0	0	0	9.81	0	0	13.8	0.1	1
2025	11	3	10	42	15	0	0	0	0	0	0	0	9.85	0	0	13	0.1	1
2025	11	3	10	52	15	0	0	0	0	0	0	0	9.88	0	0	13	0.1	1
2025	11	3	11	2	15	0	0	0	0	0	0	0	9.92	0	0	13.4	0.1	1
2025	11	3	11	12	15	0	0	0	0	0	0	0	9.95	0	0	13.4	0.1	1
2025	11	3	11	22	15	0	0	0	0	0	0	0	9.98	0	0	13.6	0.1	1
2025	11	3	11	32	15	0	0	0	0	0	0	0	10.01	0	0	13.6	0.1	1
2025	11	3	11	42	15	0	0	0	0	0	0	0	10.04	0	0	13.4	0.1	1
2025	11	3	11	52	15	0	0	0	0	0	0	0	10.07	0	0	13.2	0.1	1
2025	11	3	12	2	15	0	0	0	0	0	0	0	10.09	0	0	13.4	0.1	1
2025	11	3	12	12	15	0	0	0	0	0	0	0	10.12	0	0	13.2	0.1	1
2025	11	3	12	22	15	0	0	0	0	0	0	0	10.15	0	0	13.2	0.1	1
2025	11	3	12	32	15	0	0	0	0	0	0	0	10.16	0	0	13.2	0.1	1
2025	11	3	12	42	15	0	0	0	0	0	0	0	10.18	0	0	13.2	0.1	1
2025	11	3	12	52	15	0	0	0	0	0	0	0	10.19	0	0	13.2	0.1	1
2025	11	3	13	2	15	0	0	0	0	0	0	0	10.2	0	0	13.2	0.1	1
2025	11	3	13	12	15	0	0	0	0	0	0	0	10.23	0	0	13.2	0.1	1
2025	11	3	13	22	15	0	0	0	0	0	0	0	10.23	0	0	13	0.1	1
2025	11	3	13	32	15	0	0	0	0	0	0	0	10.24	0	0	12.8	0.1	1
2025	11	3	13	42	15	0	0	0	0	0	0	0	10.24	0	0	12.8	0.1	1
2025	11	3	13	52	15	0	0	0	0	0	0	0	10.25	0	0	13	0.1	1
2025	11	3	14	2	15	0	0	0	0	0	0	0	10.26	0	0	13	0.1	1
2025	11	3	14	12	15	0	0	0	0	0	0	0	10.26	0	0	13.2	0.1	1
2025	11	3	14	22	15	0	0	0	0	0	0	0	10.25	0	0	13.2	0.1	1
2025	11	3	14	32	15	0	0	0	0	0	0	0	10.24	0	0	13.2	0.1	1
2025	11	3	14	42	15	0	0	0	0	0	0	0	10.23	0	0	13.2	0.1	1
2025	11	3	14	52	15	0	0	0	0	0	0	0	10.23	0	0	13.2	0.1	1
2025	11	3	15	2	15	0	0	0	0	0	0	0	10.22	0	0	13.2	0.1	1
2025	11	3	15	12	15	0	0	0	0	0	0	0	10.21	0	0	13.2	0.1	1
2025	11	3	15	22	15	0	0	0	0	0	0	0	10.19	0	0	13.2	0.1	1
2025	11	3	15	32	15	0	0	0	0	0	0	0	10.18	0	0	13.2	0.1	1
2025	11	3	15	42	15	0	0	0	0	0	0	0	10.15	0	0	13.2	0.1	1
2025	11	3	15	52	15	0	0	0	0	0	0	0	10.11	0	0	13.2	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	3	16	2	15	0	0	0	0	0	0	0	10.09	0	0	13.2	0.1	1
2025	11	3	16	12	15	0	0	0	0	0	0	0	10.08	0	0	13.2	0.1	1
2025	11	3	16	22	15	0	0	0	0	0	0	0	10.06	0	0	12.8	0.1	1
2025	11	3	16	32	15	0	0	0	0	0	0	0	10.05	0	0	12.4	0.1	1
2025	11	3	16	42	15	0	0	0	0	0	0	0	10.04	0	0	12.2	0.1	1
2025	11	3	16	52	15	0	0	0	0	0	0	0	10.04	0	0	12.2	0.1	1
2025	11	3	17	2	15	0	0	0	0	0	0	0	10.04	0	0	12	0.1	1
2025	11	3	17	12	15	0	0	0	0	0	0	0	10.03	0	0	11.8	0.1	1
2025	11	3	17	22	15	0	0	0	0	0	0	0	10.02	0	0	11.8	0.1	1
2025	11	3	17	32	15	0	0	0	0	0	0	0	10.01	0	0	11.8	0.1	1
2025	11	3	17	42	15	0	0	0	0	0	0	0	10	0	0	11.8	0.1	1
2025	11	3	17	52	15	0	0	0	0	0	0	0	9.99	0	0	11.8	0.1	1
2025	11	3	18	2	15	0	0	0	0	0	0	0	9.98	0	0	11.8	0.1	1
2025	11	3	18	12	15	0	0	0	0	0	0	0	9.97	0	0	11.4	0.1	1
2025	11	3	18	22	15	0	0	0	0	0	0	0	9.95	0	0	11.6	0.1	1
2025	11	3	18	32	15	0	0	0	0	0	0	0	9.94	0	0	11.4	0.1	1
2025	11	3	18	42	15	0	0	0	0	0	0	0	9.92	0	0	11.2	0.1	1
2025	11	3	18	52	15	0	0	0	0	0	0	0	9.9	0	0	11.4	0.1	1
2025	11	3	19	2	15	0	0	0	0	0	0	0	9.88	0	0	11.4	0.1	1
2025	11	3	19	12	15	0	0	0	0	0	0	0	9.86	0	0	11.2	0.1	1
2025	11	3	19	22	15	0	0	0	0	0	0	0	9.84	0	0	11.2	0.1	1
2025	11	3	19	32	15	0	0	0	0	0	0	0	9.82	0	0	11.2	0.1	1
2025	11	3	19	42	15	0	0	0	0	0	0	0	9.79	0	0	11.2	0.1	1
2025	11	3	19	52	15	0	0	0	0	0	0	0	9.77	0	0	11.2	0.1	1
2025	11	3	20	2	15	0	0	0	0	0	0	0	9.76	0	0	11.4	0.1	1
2025	11	3	20	12	15	0	0	0	0	0	0	0	9.73	0	0	11.6	0.1	1
2025	11	3	20	22	15	0	0	0	0	0	0	0	9.71	0	0	11.6	0.1	1
2025	11	3	20	32	15	0	0	0	0	0	0	0	9.69	0	0	11.6	0.1	1
2025	11	3	20	42	15	0	0	0	0	0	0	0	9.67	0	0	11.6	0.1	1
2025	11	3	20	52	15	0	0	0	0	0	0	0	9.65	0	0	11.6	0.1	1
2025	11	3	21	2	15	0	0	0	0	0	0	0	9.63	0	0	11.6	0.1	1
2025	11	3	21	12	15	0	0	0	0	0	0	0	9.61	0	0	11.6	0.1	1
2025	11	3	21	22	15	0	0	0	0	0	0	0	9.59	0	0	11.6	0.1	1
2025	11	3	21	32	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1
2025	11	3	21	42	15	0	0	0	0	0	0	0	9.54	0	0	11.6	0.1	1
2025	11	3	21	52	15	0	0	0	0	0	0	0	9.53	0	0	11.6	0.1	1
2025	11	3	22	2	15	0	0	0	0	0	0	0	9.5	0	0	11.6	0.1	1
2025	11	3	22	12	15	0	0	0	0	0	0	0	9.48	0	0	11.6	0.1	1
2025	11	3	22	22	15	0	0	0	0	0	0	0	9.46	0	0	11.6	0.1	1
2025	11	3	22	32	15	0	0	0	0	0	0	0	9.44	0	0	11.6	0.1	1
2025	11	3	22	42	15	0	0	0	0	0	0	0	9.43	0	0	11.6	0.1	1
2025	11	3	22	52	15	0	0	0	0	0	0	0	9.41	0	0	11.6	0.1	1
2025	11	3	23	2	15	0	0	0	0	0	0	0	9.39	0	0	11.6	0.1	1
2025	11	3	23	12	15	0	0	0	0	0	0	0	9.37	0	0	11.6	0.1	1
2025	11	3	23	22	15	0	0	0	0	0	0	0	9.37	0	0	11.6	0.1	1
2025	11	3	23	32	15	0	0	0	0	0	0	0	9.34	0	0	11.6	0.1	1
2025	11	3	23	42	15	0	0	0	0	0	0	0	9.33	0	0	11.6	0.1	1
2025	11	3	23	52	15	0	0	0	0	0	0	0	9.32	0	0	11.6	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	4	0	2	15	0	0	0	0	0	0	0	9.31	0	0	11.6	0.1	1
2025	11	4	0	12	15	0	0	0	0	0	0	0	9.31	0	0	11.6	0.1	1
2025	11	4	0	22	15	0	0	0	0	0	0	0	9.29	0	0	11.6	0.1	1
2025	11	4	0	32	15	0	0	0	0	0	0	0	9.28	0	0	11.6	0.1	1
2025	11	4	0	42	15	0	0	0	0	0	0	0	9.28	0	0	11.6	0.1	1
2025	11	4	0	52	15	0	0	0	0	0	0	0	9.27	0	0	11.6	0.1	1
2025	11	4	1	2	15	0	0	0	0	0	0	0	9.26	0	0	11.6	0.1	1
2025	11	4	1	12	15	0	0	0	0	0	0	0	9.26	0	0	11.6	0.1	1
2025	11	4	1	22	15	0	0	0	0	0	0	0	9.25	0	0	11.6	0.1	1
2025	11	4	1	32	15	0	0	0	0	0	0	0	9.25	0	0	11.6	0.1	1
2025	11	4	1	42	15	0	0	0	0	0	0	0	9.25	0	0	11.6	0.1	1
2025	11	4	1	52	15	0	0	0	0	0	0	0	9.25	0	0	11.6	0.1	1
2025	11	4	2	2	15	0	0	0	0	0	0	0	9.24	0	0	11.6	0.1	1
2025	11	4	2	12	15	0	0	0	0	0	0	0	9.25	0	0	11.6	0.1	1
2025	11	4	2	22	15	0	0	0	0	0	0	0	9.24	0	0	11.6	0.1	1
2025	11	4	2	32	15	0	0	0	0	0	0	0	9.24	0	0	11.6	0.1	1
2025	11	4	2	42	15	0	0	0	0	0	0	0	9.24	0	0	11.4	0.1	1
2025	11	4	2	52	15	0	0	0	0	0	0	0	9.24	0	0	11.4	0.1	1
2025	11	4	3	2	15	0	0	0	0	0	0	0	9.24	0	0	11.4	0.1	1
2025	11	4	3	12	15	0	0	0	0	0	0	0	9.24	0	0	11.4	0.1	1
2025	11	4	3	22	15	0	0	0	0	0	0	0	9.24	0	0	11.4	0.1	1
2025	11	4	3	32	15	0	0	0	0	0	0	0	9.25	0	0	11.4	0.1	1
2025	11	4	3	42	15	0	0	0	0	0	0	0	9.25	0	0	11.4	0.1	1
2025	11	4	3	52	15	0	0	0	0	0	0	0	9.25	0	0	11.4	0.1	1
2025	11	4	4	2	15	0	0	0	0	0	0	0	9.26	0	0	11.4	0.1	1
2025	11	4	4	12	15	0	0	0	0	0	0	0	9.26	0	0	11.4	0.1	1
2025	11	4	4	22	15	0	0	0	0	0	0	0	9.26	0	0	11.4	0.1	1
2025	11	4	4	32	15	0	0	0	0	0	0	0	9.27	0	0	11.4	0.1	1
2025	11	4	4	42	15	0	0	0	0	0	0	0	9.27	0	0	11.4	0.1	1
2025	11	4	4	52	15	0	0	0	0	0	0	0	9.28	0	0	11.4	0.1	1
2025	11	4	5	2	15	0	0	0	0	0	0	0	9.28	0	0	11.4	0.1	1
2025	11	4	5	12	15	0	0	0	0	0	0	0	9.28	0	0	11.4	0.1	1
2025	11	4	5	22	15	0	0	0	0	0	0	0	9.29	0	0	11.4	0.1	1
2025	11	4	5	32	15	0	0	0	0	0	0	0	9.29	0	0	11.4	0.1	1
2025	11	4	5	42	15	0	0	0	0	0	0	0	9.29	0	0	11.4	0.1	1
2025	11	4	5	52	15	0	0	0	0	0	0	0	9.29	0	0	11.4	0.1	1
2025	11	4	6	2	15	0	0	0	0	0	0	0	9.3	0	0	11.4	0.1	1
2025	11	4	6	12	15	0	0	0	0	0	0	0	9.3	0	0	11.4	0.1	1
2025	11	4	6	22	15	0	0	0	0	0	0	0	9.3	0	0	11.4	0.1	1
2025	11	4	6	32	15	0	0	0	0	0	0	0	9.3	0	0	11.4	0.1	1
2025	11	4	6	42	15	0	0	0	0	0	0	0	9.31	0	0	11.4	0.1	1
2025	11	4	6	52	15	0	0	0	0	0	0	0	9.31	0	0	11.4	0.1	1
2025	11	4	7	2	15	0	0	0	0	0	0	0	9.32	0	0	11.4	0.1	1
2025	11	4	7	12	15	0	0	0	0	0	0	0	9.32	0	0	11.4	0.1	1
2025	11	4	7	22	15	0	0	0	0	0	0	0	9.32	0	0	11.4	0.1	1
2025	11	4	7	32	15	0	0	0	0	0	0	0	9.33	0	0	11.4	0.1	1
2025	11	4	7	42	15	0	0	0	0	0	0	0	9.34	0	0	11.4	0.1	1
2025	11	4	7	52	15	0	0	0	0	0	0	0	9.34	0	0	11.4	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	4	8	2	15	0	0	0	0	0	0	0	9.35	0	0	11.8	0.1	1
2025	11	4	8	12	15	0	0	0	0	0	0	0	9.36	0	0	12	0.1	1
2025	11	4	8	22	15	0	0	0	0	0	0	0	9.36	0	0	12.2	0.1	1
2025	11	4	8	32	15	0	0	0	0	0	0	0	9.37	0	0	12.4	0.1	1
2025	11	4	8	42	15	0	0	0	0	0	0	0	9.4	0	0	12.4	0.1	1
2025	11	4	8	52	15	0	0	0	0	0	0	0	9.44	0	0	12.6	0.1	1
2025	11	4	9	2	15	0	0	0	0	0	0	0	9.47	0	0	12.6	0.1	1
2025	11	4	9	12	15	0	0	0	0	0	0	0	9.52	0	0	12.6	0.1	1
2025	11	4	9	22	15	0	0	0	0	0	0	0	9.56	0	0	12.6	0.1	1
2025	11	4	9	32	15	0	0	0	0	0	0	0	9.59	0	0	12.8	0.1	1
2025	11	4	9	42	15	0	0	0	0	0	0	0	9.64	0	0	12.8	0.1	1
2025	11	4	9	52	15	0	0	0	0	0	0	0	9.69	0	0	12.8	0.1	1
2025	11	4	10	2	15	0	0	0	0	0	0	0	9.72	0	0	12.2	0.1	1
2025	11	4	10	12	15	0	0	0	0	0	0	0	9.75	0	0	12.2	0.1	1
2025	11	4	10	22	15	0	0	0	0	0	0	0	9.8	0	0	12.4	0.1	1
2025	11	4	10	32	15	0	0	0	0	0	0	0	9.83	0	0	13	0.1	1
2025	11	4	10	42	15	0	0	0	0	0	0	0	9.87	0	0	13	0.1	1
2025	11	4	10	52	15	0	0	0	0	0	0	0	9.9	0	0	13	0.1	1
2025	11	4	11	2	15	0	0	0	0	0	0	0	9.93	0	0	13	0.1	1
2025	11	4	11	12	15	0	0	0	0	0	0	0	9.96	0	0	13	0.1	1
2025	11	4	11	22	15	0	0	0	0	0	0	0	10	0	0	13	0.1	1
2025	11	4	11	32	15	0	0	0	0	0	0	0	10.02	0	0	13	0.1	1
2025	11	4	11	42	15	0	0	0	0	0	0	0	10.06	0	0	13	0.1	1
2025	11	4	11	52	15	0	0	0	0	0	0	0	10.08	0	0	12.8	0.1	1
2025	11	4	12	2	15	0	0	0	0	0	0	0	10.11	0	0	13	0.1	1
2025	11	4	12	12	15	0	0	0	0	0	0	0	10.13	0	0	12.8	0.1	1
2025	11	4	12	22	15	0	0	0	0	0	0	0	10.15	0	0	12.8	0.1	1
2025	11	4	12	32	15	0	0	0	0	0	0	0	10.17	0	0	12.8	0.1	1
2025	11	4	12	42	15	0	0	0	0	0	0	0	10.18	0	0	12.8	0.1	1
2025	11	4	12	52	15	0	0	0	0	0	0	0	10.19	0	0	12.8	0.1	1
2025	11	4	13	2	15	0	0	0	0	0	0	0	10.21	0	0	12.8	0.1	1
2025	11	4	13	12	15	0	0	0	0	0	0	0	10.23	0	0	12.8	0.1	1
2025	11	4	13	22	15	0	0	0	0	0	0	0	10.24	0	0	12.8	0.1	1
2025	11	4	13	32	15	0	0	0	0	0	0	0	10.24	0	0	12.8	0.1	1
2025	11	4	13	42	15	0	0	0	0	0	0	0	10.24	0	0	12.8	0.1	1
2025	11	4	13	52	15	0	0	0	0	0	0	0	10.24	0	0	12.8	0.1	1
2025	11	4	14	2	15	0	0	0	0	0	0	0	10.25	0	0	12.8	0.1	1
2025	11	4	14	12	15	0	0	0	0	0	0	0	10.24	0	0	12.8	0.1	1
2025	11	4	14	22	15	0	0	0	0	0	0	0	10.24	0	0	12.8	0.1	1
2025	11	4	14	32	15	0	0	0	0	0	0	0	10.23	0	0	12.8	0.1	1
2025	11	4	14	42	15	0	0	0	0	0	0	0	10.22	0	0	12.8	0.1	1
2025	11	4	14	52	15	0	0	0	0	0	0	0	10.21	0	0	12.8	0.1	1
2025	11	4	15	2	15	0	0	0	0	0	0	0	10.2	0	0	12.8	0.1	1
2025	11	4	15	12	15	0	0	0	0	0	0	0	10.2	0	0	12.8	0.1	1
2025	11	4	15	22	15	0	0	0	0	0	0	0	10.18	0	0	12.8	0.1	1
2025	11	4	15	32	15	0	0	0	0	0	0	0	10.16	0	0	12.8	0.1	1
2025	11	4	15	42	15	0	0	0	0	0	0	0	10.12	0	0	12.8	0.1	1
2025	11	4	15	52	15	0	0	0	0	0	0	0	10.08	0	0	12.8	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	4	16	2	15	0	0	0	0	0	0	0	10.06	0	0	12.8	0.1	1
2025	11	4	16	12	15	0	0	0	0	0	0	0	10.03	0	0	12.8	0.1	1
2025	11	4	16	22	15	0	0	0	0	0	0	0	10.01	0	0	12	0.1	1
2025	11	4	16	32	15	0	0	0	0	0	0	0	10.01	0	0	11.6	0.1	1
2025	11	4	16	42	15	0	0	0	0	0	0	0	10.01	0	0	11.4	0.1	1
2025	11	4	16	52	15	0	0	0	0	0	0	0	10	0	0	11.6	0.1	1
2025	11	4	17	2	15	0	0	0	0	0	0	0	9.99	0	0	11.6	0.1	1
2025	11	4	17	12	15	0	0	0	0	0	0	0	9.99	0	0	11.2	0.1	1
2025	11	4	17	22	15	0	0	0	0	0	0	0	9.98	0	0	11.2	0.1	1
2025	11	4	17	32	15	0	0	0	0	0	0	0	9.97	0	0	11	0.1	1
2025	11	4	17	42	15	0	0	0	0	0	0	0	9.95	0	0	11	0.1	1
2025	11	4	17	52	15	0	0	0	0	0	0	0	9.95	0	0	10.8	0.1	1
2025	11	4	18	2	15	0	0	0	0	0	0	0	9.93	0	0	10.8	0.1	1
2025	11	4	18	12	15	0	0	0	0	0	0	0	9.92	0	0	10.8	0.1	1
2025	11	4	18	22	15	0	0	0	0	0	0	0	9.91	0	0	10.8	0.1	1
2025	11	4	18	32	15	0	0	0	0	0	0	0	9.89	0	0	10.8	0.1	1
2025	11	4	18	42	15	0	0	0	0	0	0	0	9.88	0	0	10.8	0.1	1
2025	11	4	18	52	15	0	0	0	0	0	0	0	9.86	0	0	11	0.1	1
2025	11	4	19	2	15	0	0	0	0	0	0	0	9.84	0	0	11.4	0.1	1
2025	11	4	19	12	15	0	0	0	0	0	0	0	9.82	0	0	11.4	0.1	1
2025	11	4	19	22	15	0	0	0	0	0	0	0	9.8	0	0	11.4	0.1	1
2025	11	4	19	32	15	0	0	0	0	0	0	0	9.78	0	0	11.6	0.1	1
2025	11	4	19	42	15	0	0	0	0	0	0	0	9.76	0	0	11.6	0.1	1
2025	11	4	19	52	15	0	0	0	0	0	0	0	9.73	0	0	11.6	0.1	1
2025	11	4	20	2	15	0	0	0	0	0	0	0	9.71	0	0	11.6	0.1	1
2025	11	4	20	12	15	0	0	0	0	0	0	0	9.69	0	0	11.6	0.1	1
2025	11	4	20	22	15	0	0	0	0	0	0	0	9.66	0	0	11.6	0.1	1
2025	11	4	20	32	15	0	0	0	0	0	0	0	9.64	0	0	11.6	0.1	1
2025	11	4	20	42	15	0	0	0	0	0	0	0	9.62	0	0	11.6	0.1	1
2025	11	4	20	52	15	0	0	0	0	0	0	0	9.59	0	0	11.6	0.1	1
2025	11	4	21	2	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1
2025	11	4	21	12	15	0	0	0	0	0	0	0	9.54	0	0	11.6	0.1	1
2025	11	4	21	22	15	0	0	0	0	0	0	0	9.52	0	0	11.6	0.1	1
2025	11	4	21	32	15	0	0	0	0	0	0	0	9.5	0	0	11.6	0.1	1
2025	11	4	21	42	15	0	0	0	0	0	0	0	9.48	0	0	11.6	0.1	1
2025	11	4	21	52	15	0	0	0	0	0	0	0	9.45	0	0	11.6	0.1	1
2025	11	4	22	2	15	0	0	0	0	0	0	0	9.43	0	0	11.6	0.1	1
2025	11	4	22	12	15	0	0	0	0	0	0	0	9.41	0	0	11.6	0.1	1
2025	11	4	22	22	15	0	0	0	0	0	0	0	9.39	0	0	11.6	0.1	1
2025	11	4	22	32	15	0	0	0	0	0	0	0	9.37	0	0	11.6	0.1	1
2025	11	4	22	42	15	0	0	0	0	0	0	0	9.35	0	0	11.6	0.1	1
2025	11	4	22	52	15	0	0	0	0	0	0	0	9.33	0	0	11.6	0.1	1
2025	11	4	23	2	15	0	0	0	0	0	0	0	9.31	0	0	11.6	0.1	1
2025	11	4	23	12	15	0	0	0	0	0	0	0	9.29	0	0	11.6	0.1	1
2025	11	4	23	22	15	0	0	0	0	0	0	0	9.28	0	0	11.6	0.1	1
2025	11	4	23	32	15	0	0	0	0	0	0	0	9.26	0	0	11.6	0.1	1
2025	11	4	23	42	15	0	0	0	0	0	0	0	9.25	0	0	11.6	0.1	1
2025	11	4	23	52	15	0	0	0	0	0	0	0	9.24	0	0	11.6	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	5	0	2	15	0	0	0	0	0	0	0	9.23	0	0	11.6	0.1	1
2025	11	5	0	12	15	0	0	0	0	0	0	0	9.22	0	0	11.6	0.1	1
2025	11	5	0	22	15	0	0	0	0	0	0	0	9.22	0	0	11.6	0.1	1
2025	11	5	0	32	15	0	0	0	0	0	0	0	9.21	0	0	11.6	0.1	1
2025	11	5	0	42	15	0	0	0	0	0	0	0	9.2	0	0	11.6	0.1	1
2025	11	5	0	52	15	0	0	0	0	0	0	0	9.2	0	0	11.6	0.1	1
2025	11	5	1	2	15	0	0	0	0	0	0	0	9.19	0	0	11.6	0.1	1
2025	11	5	1	12	15	0	0	0	0	0	0	0	9.19	0	0	11.6	0.1	1
2025	11	5	1	22	15	0	0	0	0	0	0	0	9.18	0	0	11.6	0.1	1
2025	11	5	1	32	15	0	0	0	0	0	0	0	9.18	0	0	11.6	0.1	1
2025	11	5	1	42	15	0	0	0	0	0	0	0	9.18	0	0	11.6	0.1	1
2025	11	5	1	52	15	0	0	0	0	0	0	0	9.18	0	0	11.6	0.1	1
2025	11	5	2	2	15	0	0	0	0	0	0	0	9.18	0	0	11.6	0.1	1
2025	11	5	2	12	15	0	0	0	0	0	0	0	9.18	0	0	11.6	0.1	1
2025	11	5	2	22	15	0	0	0	0	0	0	0	9.19	0	0	11.6	0.1	1
2025	11	5	2	32	15	0	0	0	0	0	0	0	9.19	0	0	11.6	0.1	1
2025	11	5	2	42	15	0	0	0	0	0	0	0	9.2	0	0	11.6	0.1	1
2025	11	5	2	52	15	0	0	0	0	0	0	0	9.21	0	0	11.6	0.1	1
2025	11	5	3	2	15	0	0	0	0	0	0	0	9.21	0	0	11.6	0.1	1
2025	11	5	3	12	15	0	0	0	0	0	0	0	9.22	0	0	11.6	0.1	1
2025	11	5	3	22	15	0	0	0	0	0	0	0	9.23	0	0	11.6	0.1	1
2025	11	5	3	32	15	0	0	0	0	0	0	0	9.24	0	0	11.6	0.1	1
2025	11	5	3	42	15	0	0	0	0	0	0	0	9.24	0	0	11.6	0.1	1
2025	11	5	3	52	15	0	0	0	0	0	0	0	9.25	0	0	11.6	0.1	1
2025	11	5	4	2	15	0	0	0	0	0	0	0	9.26	0	0	11.6	0.1	1
2025	11	5	4	12	15	0	0	0	0	0	0	0	9.27	0	0	11.6	0.1	1
2025	11	5	4	22	15	0	0	0	0	0	0	0	9.28	0	0	11.6	0.1	1
2025	11	5	4	32	15	0	0	0	0	0	0	0	9.28	0	0	11.6	0.1	1
2025	11	5	4	42	15	0	0	0	0	0	0	0	9.3	0	0	11.4	0.1	1
2025	11	5	4	52	15	0	0	0	0	0	0	0	9.31	0	0	11.4	0.1	1
2025	11	5	5	2	15	0	0	0	0	0	0	0	9.32	0	0	11.4	0.1	1
2025	11	5	5	12	15	0	0	0	0	0	0	0	9.34	0	0	11.4	0.1	1
2025	11	5	5	22	15	0	0	0	0	0	0	0	9.34	0	0	11.4	0.1	1
2025	11	5	5	32	15	0	0	0	0	0	0	0	9.35	0	0	11.4	0.1	1
2025	11	5	5	42	15	0	0	0	0	0	0	0	9.37	0	0	11.4	0.1	1
2025	11	5	5	52	15	0	0	0	0	0	0	0	9.38	0	0	11.4	0.1	1
2025	11	5	6	2	15	0	0	0	0	0	0	0	9.39	0	0	11.4	0.1	1
2025	11	5	6	12	15	0	0	0	0	0	0	0	9.4	0	0	11.4	0.1	1
2025	11	5	6	22	15	0	0	0	0	0	0	0	9.4	0	0	11.4	0.1	1
2025	11	5	6	32	15	0	0	0	0	0	0	0	9.41	0	0	11.4	0.1	1
2025	11	5	6	42	15	0	0	0	0	0	0	0	9.42	0	0	11.4	0.1	1
2025	11	5	6	52	15	0	0	0	0	0	0	0	9.43	0	0	11.4	0.1	1
2025	11	5	7	2	15	0	0	0	0	0	0	0	9.43	0	0	11.4	0.1	1
2025	11	5	7	12	15	0	0	0	0	0	0	0	9.44	0	0	11.4	0.1	1
2025	11	5	7	22	15	0	0	0	0	0	0	0	9.45	0	0	11.4	0.1	1
2025	11	5	7	32	15	0	0	0	0	0	0	0	9.46	0	0	11.4	0.1	1
2025	11	5	7	42	15	0	0	0	0	0	0	0	9.46	0	0	11.4	0.1	1
2025	11	5	7	52	15	0	0	0	0	0	0	0	9.47	0	0	11.4	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	5	8	2	15	0	0	0	0	0	0	0	9.49	0	0	11.6	0.1	1
2025	11	5	8	12	15	0	0	0	0	0	0	0	9.49	0	0	11.8	0.1	1
2025	11	5	8	22	15	0	0	0	0	0	0	0	9.51	0	0	12	0.1	1
2025	11	5	8	32	15	0	0	0	0	0	0	0	9.52	0	0	12.2	0.1	1
2025	11	5	8	42	15	0	0	0	0	0	0	0	9.55	0	0	12.4	0.1	1
2025	11	5	8	52	15	0	0	0	0	0	0	0	9.61	0	0	12.4	0.1	1
2025	11	5	9	2	15	0	0	0	0	0	0	0	9.64	0	0	12.6	0.1	1
2025	11	5	9	12	15	0	0	0	0	0	0	0	9.67	0	0	12.4	0.1	1
2025	11	5	9	22	15	0	0	0	0	0	0	0	9.67	0	0	12.4	0.1	1
2025	11	5	9	32	15	0	0	0	0	0	0	0	9.71	0	0	11.8	0.1	1
2025	11	5	9	42	15	0	0	0	0	0	0	0	9.78	0	0	12	0.1	1
2025	11	5	9	52	15	0	0	0	0	0	0	0	9.82	0	0	12	0.1	1
2025	11	5	10	2	15	0	0	0	0	0	0	0	9.87	0	0	12	0.1	1
2025	11	5	10	12	15	0	0	0	0	0	0	0	9.9	0	0	12	0.1	1
2025	11	5	10	22	15	0	0	0	0	0	0	0	9.88	0	0	11.8	0.1	1
2025	11	5	10	32	15	0	0	0	0	0	0	0	9.91	0	0	11.8	0.1	1
2025	11	5	10	42	15	0	0	0	0	0	0	0	9.93	0	0	12	0.1	1
2025	11	5	10	52	15	0	0	0	0	0	0	0	10	0	0	12.4	0.1	1
2025	11	5	11	2	15	0	0	0	0	0	0	0	10.04	0	0	12.8	0.1	1
2025	11	5	11	12	15	0	0	0	0	0	0	0	10.08	0	0	12.8	0.1	1
2025	11	5	11	22	15	0	0	0	0	0	0	0	10.1	0	0	12.6	0.1	1
2025	11	5	11	32	15	0	0	0	0	0	0	0	10.14	0	0	12.8	0.1	1
2025	11	5	11	42	15	0	0	0	0	0	0	0	10.16	0	0	12.8	0.1	1
2025	11	5	11	52	15	0	0	0	0	0	0	0	10.2	0	0	12.8	0.1	1
2025	11	5	12	2	15	0	0	0	0	0	0	0	10.12	0	0	12.4	0.1	1
2025	11	5	12	12	15	0	0	0	0	0	0	0	10.14	0	0	12.8	0.1	1
2025	11	5	12	22	15	0	0	0	0	0	0	0	10.16	0	0	12.8	0.1	1
2025	11	5	12	32	15	0	0	0	0	0	0	0	10.19	0	0	12.8	0.1	1
2025	11	5	12	42	15	0	0	0	0	0	0	0	10.25	0	0	12.8	0.1	1
2025	11	5	12	52	15	0	0	0	0	0	0	0	10.27	0	0	12.8	0.1	1
2025	11	5	13	2	15	0	0	0	0	0	0	0	10.27	0	0	12.8	0.1	1
2025	11	5	13	12	15	0	0	0	0	0	0	0	10.29	0	0	12.8	0.1	1
2025	11	5	13	22	15	0	0	0	0	0	0	0	10.31	0	0	12.8	0.1	1
2025	11	5	13	32	15	0	0	0	0	0	0	0	10.3	0	0	12.8	0.1	1
2025	11	5	13	42	15	0	0	0	0	0	0	0	10.31	0	0	13	0.1	1
2025	11	5	13	52	15	0	0	0	0	0	0	0	10.31	0	0	13.6	0.1	1
2025	11	5	14	2	15	0	0	0	0	0	0	0	10.31	0	0	13.4	0.1	1
2025	11	5	14	12	15	0	0	0	0	0	0	0	10.31	0	0	13.4	0.1	1
2025	11	5	14	22	15	0	0	0	0	0	0	0	10.3	0	0	13.4	0.1	1
2025	11	5	14	32	15	0	0	0	0	0	0	0	10.31	0	0	13.4	0.1	1
2025	11	5	14	42	15	0	0	0	0	0	0	0	10.3	0	0	13.4	0.1	1
2025	11	5	14	52	15	0	0	0	0	0	0	0	10.29	0	0	13.4	0.1	1
2025	11	5	15	2	15	0	0	0	0	0	0	0	10.27	0	0	13.4	0.1	1
2025	11	5	15	12	15	0	0	0	0	0	0	0	10.23	0	0	13.4	0.1	1
2025	11	5	15	22	15	0	0	0	0	0	0	0	10.19	0	0	12.4	0.1	1
2025	11	5	15	32	15	0	0	0	0	0	0	0	10.2	0	0	13.2	0.1	1
2025	11	5	15	42	15	0	0	0	0	0	0	0	10.19	0	0	13.4	0.1	1
2025	11	5	15	52	15	0	0	0	0	0	0	0	10.16	0	0	12	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	5	16	2	15	0	0	0	0	0	0	0	10.16	0	0	12	0.1	1
2025	11	5	16	12	15	0	0	0	0	0	0	0	10.16	0	0	11.8	0.1	1
2025	11	5	16	22	15	0	0	0	0	0	0	0	10.16	0	0	11.6	0.1	1
2025	11	5	16	32	15	0	0	0	0	0	0	0	10.16	0	0	11.6	0.1	1
2025	11	5	16	42	15	0	0	0	0	0	0	0	10.15	0	0	11.6	0.1	1
2025	11	5	16	52	15	0	0	0	0	0	0	0	10.16	0	0	11.4	0.1	1
2025	11	5	17	2	15	0	0	0	0	0	0	0	10.15	0	0	11	0.1	1
2025	11	5	17	12	15	0	0	0	0	0	0	0	10.14	0	0	11	0.1	1
2025	11	5	17	22	15	0	0	0	0	0	0	0	10.14	0	0	10.8	0.1	1
2025	11	5	17	32	15	0	0	0	0	0	0	0	10.14	0	0	10.8	0.1	1
2025	11	5	17	42	15	0	0	0	0	0	0	0	10.13	0	0	10.8	0.1	1
2025	11	5	17	52	15	0	0	0	0	0	0	0	10.12	0	0	10.8	0.1	1
2025	11	5	18	2	15	0	0	0	0	0	0	0	10.11	0	0	10.8	0.1	1
2025	11	5	18	12	15	0	0	0	0	0	0	0	10.11	0	0	10.8	0.1	1
2025	11	5	18	22	15	0	0	0	0	0	0	0	10.09	0	0	10.8	0.1	1
2025	11	5	18	32	15	0	0	0	0	0	0	0	10.09	0	0	10.8	0.1	1
2025	11	5	18	42	15	0	0	0	0	0	0	0	10.08	0	0	11	0.1	1
2025	11	5	18	52	15	0	0	0	0	0	0	0	10.07	0	0	11	0.1	1
2025	11	5	19	2	15	0	0	0	0	0	0	0	10.06	0	0	11	0.1	1
2025	11	5	19	12	15	0	0	0	0	0	0	0	10.05	0	0	11	0.1	1
2025	11	5	19	22	15	0	0	0	0	0	0	0	10.03	0	0	11	0.1	1
2025	11	5	19	32	15	0	0	0	0	0	0	0	10.02	0	0	11	0.1	1
2025	11	5	19	42	15	0	0	0	0	0	0	0	10.01	0	0	11	0.1	1
2025	11	5	19	52	15	0	0	0	0	0	0	0	10	0	0	11	0.1	1
2025	11	5	20	2	15	0	0	0	0	0	0	0	9.99	0	0	10.8	0.1	1
2025	11	5	20	12	15	0	0	0	0	0	0	0	9.97	0	0	10.8	0.1	1
2025	11	5	20	22	15	0	0	0	0	0	0	0	9.96	0	0	10.8	0.1	1
2025	11	5	20	32	15	0	0	0	0	0	0	0	9.95	0	0	10.8	0.1	1
2025	11	5	20	42	15	0	0	0	0	0	0	0	9.94	0	0	10.8	0.1	1
2025	11	5	20	52	15	0	0	0	0	0	0	0	9.92	0	0	10.8	0.1	1
2025	11	5	21	2	15	0	0	0	0	0	0	0	9.91	0	0	10.8	0.1	1
2025	11	5	21	12	15	0	0	0	0	0	0	0	9.9	0	0	10.8	0.1	1
2025	11	5	21	22	15	0	0	0	0	0	0	0	9.88	0	0	10.8	0.1	1
2025	11	5	21	32	15	0	0	0	0	0	0	0	9.87	0	0	10.8	0.1	1
2025	11	5	21	42	15	0	0	0	0	0	0	0	9.86	0	0	10.8	0.1	1
2025	11	5	21	52	15	0	0	0	0	0	0	0	9.85	0	0	10.8	0.1	1
2025	11	5	22	2	15	0	0	0	0	0	0	0	9.84	0	0	10.8	0.1	1
2025	11	5	22	12	15	0	0	0	0	0	0	0	9.83	0	0	10.8	0.1	1
2025	11	5	22	22	15	0	0	0	0	0	0	0	9.81	0	0	10.8	0.1	1
2025	11	5	22	32	15	0	0	0	0	0	0	0	9.81	0	0	10.8	0.1	1
2025	11	5	22	42	15	0	0	0	0	0	0	0	9.79	0	0	10.8	0.1	1
2025	11	5	22	52	15	0	0	0	0	0	0	0	9.79	0	0	10.8	0.1	1
2025	11	5	23	2	15	0	0	0	0	0	0	0	9.78	0	0	10.8	0.1	1
2025	11	5	23	12	15	0	0	0	0	0	0	0	9.77	0	0	10.8	0.1	1
2025	11	5	23	22	15	0	0	0	0	0	0	0	9.76	0	0	10.8	0.1	1
2025	11	5	23	32	15	0	0	0	0	0	0	0	9.75	0	0	10.8	0.1	1
2025	11	5	23	42	15	0	0	0	0	0	0	0	9.74	0	0	10.8	0.1	1
2025	11	5	23	52	15	0	0	0	0	0	0	0	9.74	0	0	10.8	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	6	0	2	15	0	0	0	0	0	0	0	9.73	0	0	10.8	0.1	1
2025	11	6	0	12	15	0	0	0	0	0	0	0	9.73	0	0	10.8	0.1	1
2025	11	6	0	22	15	0	0	0	0	0	0	0	9.72	0	0	10.8	0.1	1
2025	11	6	0	32	15	0	0	0	0	0	0	0	9.72	0	0	10.8	0.1	1
2025	11	6	0	42	15	0	0	0	0	0	0	0	9.72	0	0	10.8	0.1	1
2025	11	6	0	52	15	0	0	0	0	0	0	0	9.72	0	0	10.8	0.1	1
2025	11	6	1	2	15	0	0	0	0	0	0	0	9.71	0	0	10.8	0.1	1
2025	11	6	1	12	15	0	0	0	0	0	0	0	9.71	0	0	10.8	0.1	1
2025	11	6	1	22	15	0	0	0	0	0	0	0	9.71	0	0	10.8	0.1	1
2025	11	6	1	32	15	0	0	0	0	0	0	0	9.71	0	0	10.8	0.1	1
2025	11	6	1	42	15	0	0	0	0	0	0	0	9.71	0	0	10.8	0.1	1
2025	11	6	1	52	15	0	0	0	0	0	0	0	9.71	0	0	10.8	0.1	1
2025	11	6	2	2	15	0	0	0	0	0	0	0	9.71	0	0	10.8	0.1	1
2025	11	6	2	12	15	0	0	0	0	0	0	0	9.71	0	0	10.8	0.1	1
2025	11	6	2	22	15	0	0	0	0	0	0	0	9.71	0	0	10.8	0.1	1
2025	11	6	2	32	15	0	0	0	0	0	0	0	9.72	0	0	10.8	0.1	1
2025	11	6	2	42	15	0	0	0	0	0	0	0	9.72	0	0	10.8	0.1	1
2025	11	6	2	52	15	0	0	0	0	0	0	0	9.72	0	0	10.8	0.1	1
2025	11	6	3	2	15	0	0	0	0	0	0	0	9.72	0	0	10.8	0.1	1
2025	11	6	3	12	15	0	0	0	0	0	0	0	9.72	0	0	10.8	0.1	1
2025	11	6	3	22	15	0	0	0	0	0	0	0	9.73	0	0	10.8	0.1	1
2025	11	6	3	32	15	0	0	0	0	0	0	0	9.73	0	0	10.8	0.1	1
2025	11	6	3	42	15	0	0	0	0	0	0	0	9.73	0	0	10.8	0.1	1
2025	11	6	3	52	15	0	0	0	0	0	0	0	9.73	0	0	10.8	0.1	1
2025	11	6	4	2	15	0	0	0	0	0	0	0	9.73	0	0	11.2	0.1	1
2025	11	6	4	12	15	0	0	0	0	0	0	0	9.73	0	0	11.4	0.1	1
2025	11	6	4	22	15	0	0	0	0	0	0	0	9.74	0	0	11.4	0.1	1
2025	11	6	4	32	15	0	0	0	0	0	0	0	9.74	0	0	11.4	0.1	1
2025	11	6	4	42	15	0	0	0	0	0	0	0	9.74	0	0	11.4	0.1	1
2025	11	6	4	52	15	0	0	0	0	0	0	0	9.75	0	0	11.4	0.1	1
2025	11	6	5	2	15	0	0	0	0	0	0	0	9.75	0	0	11.4	0.1	1
2025	11	6	5	12	15	0	0	0	0	0	0	0	9.74	0	0	11.4	0.1	1
2025	11	6	5	22	15	0	0	0	0	0	0	0	9.75	0	0	11.4	0.1	1
2025	11	6	5	32	15	0	0	0	0	0	0	0	9.75	0	0	11.4	0.1	1
2025	11	6	5	42	15	0	0	0	0	0	0	0	9.75	0	0	11.4	0.1	1
2025	11	6	5	52	15	0	0	0	0	0	0	0	9.75	0	0	11.4	0.1	1
2025	11	6	6	2	15	0	0	0	0	0	0	0	9.75	0	0	11.4	0.1	1
2025	11	6	6	12	15	0	0	0	0	0	0	0	9.75	0	0	11.4	0.1	1
2025	11	6	6	22	15	0	0	0	0	0	0	0	9.75	0	0	11.4	0.1	1
2025	11	6	6	32	15	0	0	0	0	0	0	0	9.74	0	0	11.4	0.1	1
2025	11	6	6	42	15	0	0	0	0	0	0	0	9.74	0	0	11.4	0.1	1
2025	11	6	6	52	15	0	0	0	0	0	0	0	9.74	0	0	11.4	0.1	1
2025	11	6	7	2	15	0	0	0	0	0	0	0	9.74	0	0	11.4	0.1	1
2025	11	6	7	12	15	0	0	0	0	0	0	0	9.74	0	0	11.4	0.1	1
2025	11	6	7	22	15	0	0	0	0	0	0	0	9.74	0	0	11.4	0.1	1
2025	11	6	7	32	15	0	0	0	0	0	0	0	9.74	0	0	11.4	0.1	1
2025	11	6	7	42	15	0	0	0	0	0	0	0	9.74	0	0	11.4	0.1	1
2025	11	6	7	52	15	0	0	0	0	0	0	0	9.75	0	0	11.4	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	6	8	2	15	0	0	0	0	0	0	0	9.74	0	0	11.4	0.1	1
2025	11	6	8	12	15	0	0	0	0	0	0	0	9.74	0	0	11.6	0.1	1
2025	11	6	8	22	15	0	0	0	0	0	0	0	9.75	0	0	12	0.1	1
2025	11	6	8	32	15	0	0	0	0	0	0	0	9.76	0	0	12.2	0.1	1
2025	11	6	8	42	15	0	0	0	0	0	0	0	9.77	0	0	12.4	0.1	1
2025	11	6	8	52	15	0	0	0	0	0	0	0	9.8	0	0	12.4	0.1	1
2025	11	6	9	2	15	0	0	0	0	0	0	0	9.82	0	0	12.2	0.1	1
2025	11	6	9	12	15	0	0	0	0	0	0	0	9.86	0	0	12	0.1	1
2025	11	6	9	22	15	0	0	0	0	0	0	0	9.88	0	0	12	0.1	1
2025	11	6	9	32	15	0	0	0	0	0	0	0	9.92	0	0	12	0.1	1
2025	11	6	9	42	15	0	0	0	0	0	0	0	9.96	0	0	12	0.1	1
2025	11	6	9	52	15	0	0	0	0	0	0	0	9.99	0	0	12	0.1	1
2025	11	6	10	2	15	0	0	0	0	0	0	0	10.02	0	0	12	0.1	1
2025	11	6	10	12	15	0	0	0	0	0	0	0	10.05	0	0	12.2	0.1	1
2025	11	6	10	22	15	0	0	0	0	0	0	0	10.08	0	0	12.4	0.1	1
2025	11	6	10	32	15	0	0	0	0	0	0	0	10.11	0	0	12.8	0.1	1
2025	11	6	10	42	15	0	0	0	0	0	0	0	10.15	0	0	13	0.1	1
2025	11	6	10	52	15	0	0	0	0	0	0	0	10.18	0	0	13	0.1	1
2025	11	6	11	2	15	0	0	0	0	0	0	0	10.2	0	0	13	0.1	1
2025	11	6	11	12	15	0	0	0	0	0	0	0	10.24	0	0	13	0.1	1
2025	11	6	11	22	15	0	0	0	0	0	0	0	10.26	0	0	12.8	0.1	1
2025	11	6	11	32	15	0	0	0	0	0	0	0	10.29	0	0	12.8	0.1	1
2025	11	6	11	42	15	0	0	0	0	0	0	0	10.32	0	0	12.8	0.1	1
2025	11	6	11	52	15	0	0	0	0	0	0	0	10.34	0	0	12.8	0.1	1
2025	11	6	12	2	15	0	0	0	0	0	0	0	10.36	0	0	12.8	0.1	1
2025	11	6	12	12	15	0	0	0	0	0	0	0	10.39	0	0	12.8	0.1	1
2025	11	6	12	22	15	0	0	0	0	0	0	0	10.41	0	0	12.8	0.1	1
2025	11	6	12	32	15	0	0	0	0	0	0	0	10.44	0	0	12.8	0.1	1
2025	11	6	12	42	15	0	0	0	0	0	0	0	10.45	0	0	12.8	0.1	1
2025	11	6	12	52	15	0	0	0	0	0	0	0	10.46	0	0	12.8	0.1	1
2025	11	6	13	2	15	0	0	0	0	0	0	0	10.49	0	0	12.8	0.1	1
2025	11	6	13	12	15	0	0	0	0	0	0	0	10.5	0	0	12.8	0.1	1
2025	11	6	13	22	15	0	0	0	0	0	0	0	10.51	0	0	12.8	0.1	1
2025	11	6	13	32	15	0	0	0	0	0	0	0	10.52	0	0	12.8	0.1	1
2025	11	6	13	42	15	0	0	0	0	0	0	0	10.53	0	0	12.8	0.1	1
2025	11	6	13	52	15	0	0	0	0	0	0	0	10.54	0	0	12.8	0.1	1
2025	11	6	14	2	15	0	0	0	0	0	0	0	10.55	0	0	12.6	0.1	1
2025	11	6	14	12	15	0	0	0	0	0	0	0	10.55	0	0	12.8	0.1	1
2025	11	6	14	22	15	0	0	0	0	0	0	0	10.55	0	0	12.6	0.1	1
2025	11	6	14	32	15	0	0	0	0	0	0	0	10.55	0	0	12.6	0.1	1
2025	11	6	14	42	15	0	0	0	0	0	0	0	10.54	0	0	12.6	0.1	1
2025	11	6	14	52	15	0	0	0	0	0	0	0	10.55	0	0	12.6	0.1	1
2025	11	6	15	2	15	0	0	0	0	0	0	0	10.54	0	0	12.4	0.1	1
2025	11	6	15	12	15	0	0	0	0	0	0	0	10.53	0	0	12.6	0.1	1
2025	11	6	15	22	15	0	0	0	0	0	0	0	10.53	0	0	12.4	0.1	1
2025	11	6	15	32	15	0	0	0	0	0	0	0	10.52	0	0	12.4	0.1	1
2025	11	6	15	42	15	0	0	0	0	0	0	0	10.5	0	0	12.4	0.1	1
2025	11	6	15	52	15	0	0	0	0	0	0	0	10.48	0	0	12.4	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	6	16	2	15	0	0	0	0	0	0	0	10.46	0	0	12.4	0.1	1
2025	11	6	16	12	15	0	0	0	0	0	0	0	10.44	0	0	12.2	0.1	1
2025	11	6	16	22	15	0	0	0	0	0	0	0	10.43	0	0	11.6	0.1	1
2025	11	6	16	32	15	0	0	0	0	0	0	0	10.44	0	0	11.6	0.1	1
2025	11	6	16	42	15	0	0	0	0	0	0	0	10.43	0	0	11.4	0.1	1
2025	11	6	16	52	15	0	0	0	0	0	0	0	10.43	0	0	11.2	0.1	1
2025	11	6	17	2	15	0	0	0	0	0	0	0	10.43	0	0	11	0.1	1
2025	11	6	17	12	15	0	0	0	0	0	0	0	10.43	0	0	11	0.1	1
2025	11	6	17	22	15	0	0	0	0	0	0	0	10.43	0	0	11	0.1	1
2025	11	6	17	32	15	0	0	0	0	0	0	0	10.42	0	0	10.8	0.1	1
2025	11	6	17	42	15	0	0	0	0	0	0	0	10.41	0	0	10.8	0.1	1
2025	11	6	17	52	15	0	0	0	0	0	0	0	10.4	0	0	10.8	0.1	1
2025	11	6	18	2	15	0	0	0	0	0	0	0	10.39	0	0	10.8	0.1	1
2025	11	6	18	12	15	0	0	0	0	0	0	0	10.37	0	0	10.8	0.1	1
2025	11	6	18	22	15	0	0	0	0	0	0	0	10.36	0	0	10.8	0.1	1
2025	11	6	18	32	15	0	0	0	0	0	0	0	10.35	0	0	10.8	0.1	1
2025	11	6	18	42	15	0	0	0	0	0	0	0	10.33	0	0	10.8	0.1	1
2025	11	6	18	52	15	0	0	0	0	0	0	0	10.32	0	0	10.8	0.1	1
2025	11	6	19	2	15	0	0	0	0	0	0	0	10.3	0	0	10.8	0.1	1
2025	11	6	19	12	15	0	0	0	0	0	0	0	10.27	0	0	10.8	0.1	1
2025	11	6	19	22	15	0	0	0	0	0	0	0	10.26	0	0	11.2	0.1	1
2025	11	6	19	32	15	0	0	0	0	0	0	0	10.23	0	0	11.2	0.1	1
2025	11	6	19	42	15	0	0	0	0	0	0	0	10.22	0	0	11.2	0.1	1
2025	11	6	19	52	15	0	0	0	0	0	0	0	10.2	0	0	11	0.1	1
2025	11	6	20	2	15	0	0	0	0	0	0	0	10.18	0	0	11.4	0.1	1
2025	11	6	20	12	15	0	0	0	0	0	0	0	10.16	0	0	11.6	0.1	1
2025	11	6	20	22	15	0	0	0	0	0	0	0	10.14	0	0	11.6	0.1	1
2025	11	6	20	32	15	0	0	0	0	0	0	0	10.12	0	0	11.6	0.1	1
2025	11	6	20	42	15	0	0	0	0	0	0	0	10.1	0	0	11.4	0.1	1
2025	11	6	20	52	15	0	0	0	0	0	0	0	10.08	0	0	11.4	0.1	1
2025	11	6	21	2	15	0	0	0	0	0	0	0	10.06	0	0	11.4	0.1	1
2025	11	6	21	12	15	0	0	0	0	0	0	0	10.04	0	0	11.4	0.1	1
2025	11	6	21	22	15	0	0	0	0	0	0	0	10.02	0	0	11.4	0.1	1
2025	11	6	21	32	15	0	0	0	0	0	0	0	9.99	0	0	11.4	0.1	1
2025	11	6	21	42	15	0	0	0	0	0	0	0	9.98	0	0	11.4	0.1	1
2025	11	6	21	52	15	0	0	0	0	0	0	0	9.96	0	0	11.4	0.1	1
2025	11	6	22	2	15	0	0	0	0	0	0	0	9.93	0	0	11.4	0.1	1
2025	11	6	22	12	15	0	0	0	0	0	0	0	9.92	0	0	11.4	0.1	1
2025	11	6	22	22	15	0	0	0	0	0	0	0	9.9	0	0	11.4	0.1	1
2025	11	6	22	32	15	0	0	0	0	0	0	0	9.87	0	0	11.4	0.1	1
2025	11	6	22	42	15	0	0	0	0	0	0	0	9.86	0	0	11.4	0.1	1
2025	11	6	22	52	15	0	0	0	0	0	0	0	9.84	0	0	11.4	0.1	1
2025	11	6	23	2	15	0	0	0	0	0	0	0	9.82	0	0	11.4	0.1	1
2025	11	6	23	12	15	0	0	0	0	0	0	0	9.81	0	0	11.4	0.1	1
2025	11	6	23	22	15	0	0	0	0	0	0	0	9.79	0	0	11.4	0.1	1
2025	11	6	23	32	15	0	0	0	0	0	0	0	9.78	0	0	11.4	0.1	1
2025	11	6	23	42	15	0	0	0	0	0	0	0	9.77	0	0	11.4	0.1	1
2025	11	6	23	52	15	0	0	0	0	0	0	0	9.75	0	0	11.4	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	7	0	2	15	0	0	0	0	0	0	0	9.74	0	0	11.4	0.1	1
2025	11	7	0	12	15	0	0	0	0	0	0	0	9.73	0	0	11.4	0.1	1
2025	11	7	0	22	15	0	0	0	0	0	0	0	9.71	0	0	11.4	0.1	1
2025	11	7	0	32	15	0	0	0	0	0	0	0	9.7	0	0	11.4	0.1	1
2025	11	7	0	42	15	0	0	0	0	0	0	0	9.69	0	0	11.4	0.1	1
2025	11	7	0	52	15	0	0	0	0	0	0	0	9.68	0	0	11.4	0.1	1
2025	11	7	1	2	15	0	0	0	0	0	0	0	9.67	0	0	11.4	0.1	1
2025	11	7	1	12	15	0	0	0	0	0	0	0	9.66	0	0	11.4	0.1	1
2025	11	7	1	22	15	0	0	0	0	0	0	0	9.65	0	0	11.4	0.1	1
2025	11	7	1	32	15	0	0	0	0	0	0	0	9.65	0	0	11.4	0.1	1
2025	11	7	1	42	15	0	0	0	0	0	0	0	9.64	0	0	11.4	0.1	1
2025	11	7	1	52	15	0	0	0	0	0	0	0	9.64	0	0	11.4	0.1	1
2025	11	7	2	2	15	0	0	0	0	0	0	0	9.63	0	0	11.4	0.1	1
2025	11	7	2	12	15	0	0	0	0	0	0	0	9.63	0	0	11.4	0.1	1
2025	11	7	2	22	15	0	0	0	0	0	0	0	9.62	0	0	11.4	0.1	1
2025	11	7	2	32	15	0	0	0	0	0	0	0	9.62	0	0	11.4	0.1	1
2025	11	7	2	42	15	0	0	0	0	0	0	0	9.62	0	0	11.4	0.1	1
2025	11	7	2	52	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	7	3	2	15	0	0	0	0	0	0	0	9.62	0	0	11.4	0.1	1
2025	11	7	3	12	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	7	3	22	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	7	3	32	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	7	3	42	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	7	3	52	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	7	4	2	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	7	4	12	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	7	4	22	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	7	4	32	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	7	4	42	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	7	4	52	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	7	5	2	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	7	5	12	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	7	5	22	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	7	5	32	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	7	5	42	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1
2025	11	7	5	52	15	0	0	0	0	0	0	0	9.62	0	0	11.4	0.1	1
2025	11	7	6	2	15	0	0	0	0	0	0	0	9.62	0	0	11.4	0.1	1
2025	11	7	6	12	15	0	0	0	0	0	0	0	9.62	0	0	11.4	0.1	1
2025	11	7	6	22	15	0	0	0	0	0	0	0	9.62	0	0	11.4	0.1	1
2025	11	7	6	32	15	0	0	0	0	0	0	0	9.63	0	0	11.4	0.1	1
2025	11	7	6	42	15	0	0	0	0	0	0	0	9.63	0	0	11.4	0.1	1
2025	11	7	6	52	15	0	0	0	0	0	0	0	9.63	0	0	11.4	0.1	1
2025	11	7	7	2	15	0	0	0	0	0	0	0	9.63	0	0	11.4	0.1	1
2025	11	7	7	12	15	0	0	0	0	0	0	0	9.63	0	0	11.4	0.1	1
2025	11	7	7	22	15	0	0	0	0	0	0	0	9.64	0	0	11.4	0.1	1
2025	11	7	7	32	15	0	0	0	0	0	0	0	9.64	0	0	11.4	0.1	1
2025	11	7	7	42	15	0	0	0	0	0	0	0	9.64	0	0	11.4	0.1	1
2025	11	7	7	52	15	0	0	0	0	0	0	0	9.64	0	0	11.4	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	7	8	2	15	0	0	0	0	0	0	0	9.65	0	0	11.6	0.1	1
2025	11	7	8	12	15	0	0	0	0	0	0	0	9.65	0	0	11.8	0.1	1
2025	11	7	8	22	15	0	0	0	0	0	0	0	9.65	0	0	12	0.1	1
2025	11	7	8	32	15	0	0	0	0	0	0	0	9.66	0	0	12.2	0.1	1
2025	11	7	8	42	15	0	0	0	0	0	0	0	9.67	0	0	11.8	0.1	1
2025	11	7	8	52	15	0	0	0	0	0	0	0	9.7	0	0	11.8	0.1	1
2025	11	7	9	2	15	0	0	0	0	0	0	0	9.73	0	0	12	0.1	1
2025	11	7	9	12	15	0	0	0	0	0	0	0	9.77	0	0	11.8	0.1	1
2025	11	7	9	22	15	0	0	0	0	0	0	0	9.8	0	0	12	0.1	1.1
2025	11	7	9	32	15	0	0	0	0	0	0	0	9.83	0	0	12	0.1	1.1
2025	11	7	9	42	15	0	0	0	0	0	0	0	9.87	0	0	12	0.1	1.1
2025	11	7	9	52	15	0	0	0	0	0	0	0	9.9	0	0	12	0.1	1.1
2025	11	7	10	2	15	0	0	0	0	0	0	0	9.92	0	0	12	0.1	1.1
2025	11	7	10	12	15	0	0	0	0	0	0	0	9.96	0	0	12.2	0.1	1.1
2025	11	7	10	22	15	0	0	0	0	0	0	0	9.99	0	0	12.4	0.1	1.1
2025	11	7	10	32	15	0	0	0	0	0	0	0	10.02	0	0	12.6	0.1	1.1
2025	11	7	10	42	15	0	0	0	0	0	0	0	10.05	0	0	13	0.1	1.1
2025	11	7	10	52	15	0	0	0	0	0	0	0	10.09	0	0	13	0.1	1.1
2025	11	7	11	2	15	0	0	0	0	0	0	0	10.11	0	0	13	0.1	1.1
2025	11	7	11	12	15	0	0	0	0	0	0	0	10.14	0	0	13	0.1	1.1
2025	11	7	11	22	15	0	0	0	0	0	0	0	10.15	0	0	12.8	0.1	1.1
2025	11	7	11	32	15	0	0	0	0	0	0	0	10.18	0	0	13.8	0.1	1.1
2025	11	7	11	42	15	0	0	0	0	0	0	0	10.2	0	0	13.8	0.1	1.1
2025	11	7	11	52	15	0	0	0	0	0	0	0	10.22	0	0	13.8	0.1	1.1
2025	11	7	12	2	15	0	0	0	0	0	0	0	10.24	0	0	13.6	0.1	1.1
2025	11	7	12	12	15	0	0	0	0	0	0	0	10.25	0	0	13.8	0.1	1.1
2025	11	7	12	22	15	0	0	0	0	0	0	0	10.26	0	0	13.6	0.1	1.1
2025	11	7	12	32	15	0	0	0	0	0	0	0	10.29	0	0	13.6	0.1	1.1
2025	11	7	12	42	15	0	0	0	0	0	0	0	10.3	0	0	13.6	0.1	1.1
2025	11	7	12	52	15	0	0	0	0	0	0	0	10.31	0	0	13.4	0.1	1.1
2025	11	7	13	2	15	0	0	0	0	0	0	0	10.33	0	0	13.6	0.1	1.1
2025	11	7	13	12	15	0	0	0	0	0	0	0	10.33	0	0	13.6	0.1	1.1
2025	11	7	13	22	15	0	0	0	0	0	0	0	10.35	0	0	13.6	0.1	1.1
2025	11	7	13	32	15	0	0	0	0	0	0	0	10.36	0	0	13.4	0.1	1.1
2025	11	7	13	42	15	0	0	0	0	0	0	0	10.37	0	0	13.2	0.1	1.1
2025	11	7	13	52	15	0	0	0	0	0	0	0	10.36	0	0	12.8	0.1	1.1
2025	11	7	14	2	15	0	0	0	0	0	0	0	10.36	0	0	12.6	0.1	1.1
2025	11	7	14	12	15	0	0	0	0	0	0	0	10.35	0	0	12.8	0.1	1.1
2025	11	7	14	22	15	0	0	0	0	0	0	0	10.35	0	0	12.8	0.1	1.1
2025	11	7	14	32	15	0	0	0	0	0	0	0	10.35	0	0	12.8	0.1	1.1
2025	11	7	14	42	15	0	0	0	0	0	0	0	10.33	0	0	12.8	0.1	1.1
2025	11	7	14	52	15	0	0	0	0	0	0	0	10.33	0	0	12.8	0.1	1.1
2025	11	7	15	2	15	0	0	0	0	0	0	0	10.32	0	0	12.8	0.1	1.1
2025	11	7	15	12	15	0	0	0	0	0	0	0	10.31	0	0	12.6	0.1	1.1
2025	11	7	15	22	15	0	0	0	0	0	0	0	10.3	0	0	12.6	0.1	1.1
2025	11	7	15	32	15	0	0	0	0	0	0	0	10.27	0	0	12.6	0.1	1.1
2025	11	7	15	42	15	0	0	0	0	0	0	0	10.26	0	0	12.8	0.1	1.1
2025	11	7	15	52	15	0	0	0	0	0	0	0	10.23	0	0	12.8	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	7	16	2	15	0	0	0	0	0	0	0	10.21	0	0	12.8	0.1	1.1
2025	11	7	16	12	15	0	0	0	0	0	0	0	10.19	0	0	12.4	0.1	1.1
2025	11	7	16	22	15	0	0	0	0	0	0	0	10.18	0	0	11.8	0.1	1.1
2025	11	7	16	32	15	0	0	0	0	0	0	0	10.17	0	0	11.6	0.1	1.1
2025	11	7	16	42	15	0	0	0	0	0	0	0	10.17	0	0	11.4	0.1	1.1
2025	11	7	16	52	15	0	0	0	0	0	0	0	10.16	0	0	11.4	0.1	1.1
2025	11	7	17	2	15	0	0	0	0	0	0	0	10.16	0	0	11	0.1	1.1
2025	11	7	17	12	15	0	0	0	0	0	0	0	10.15	0	0	11	0.1	1.1
2025	11	7	17	22	15	0	0	0	0	0	0	0	10.14	0	0	10.8	0.1	1.1
2025	11	7	17	32	15	0	0	0	0	0	0	0	10.13	0	0	10.8	0.1	1.1
2025	11	7	17	42	15	0	0	0	0	0	0	0	10.13	0	0	10.8	0.1	1.1
2025	11	7	17	52	15	0	0	0	0	0	0	0	10.12	0	0	10.8	0.1	1.1
2025	11	7	18	2	15	0	0	0	0	0	0	0	10.1	0	0	10.8	0.1	1.1
2025	11	7	18	12	15	0	0	0	0	0	0	0	10.09	0	0	10.8	0.1	1.1
2025	11	7	18	22	15	0	0	0	0	0	0	0	10.07	0	0	10.8	0.1	1.1
2025	11	7	18	32	15	0	0	0	0	0	0	0	10.06	0	0	10.8	0.1	1.1
2025	11	7	18	42	15	0	0	0	0	0	0	0	10.04	0	0	10.8	0.1	1.1
2025	11	7	18	52	15	0	0	0	0	0	0	0	10.02	0	0	10.8	0.1	1.1
2025	11	7	19	2	15	0	0	0	0	0	0	0	10	0	0	10.8	0.1	1.1
2025	11	7	19	12	15	0	0	0	0	0	0	0	9.99	0	0	10.8	0.1	1.1
2025	11	7	19	22	15	0	0	0	0	0	0	0	9.97	0	0	10.8	0.1	1.1
2025	11	7	19	32	15	0	0	0	0	0	0	0	9.95	0	0	10.8	0.1	1.1
2025	11	7	19	42	15	0	0	0	0	0	0	0	9.92	0	0	10.8	0.1	1.1
2025	11	7	19	52	15	0	0	0	0	0	0	0	9.9	0	0	11.4	0.1	1.1
2025	11	7	20	2	15	0	0	0	0	0	0	0	9.88	0	0	11.6	0.1	1.1
2025	11	7	20	12	15	0	0	0	0	0	0	0	9.86	0	0	11.6	0.1	1.1
2025	11	7	20	22	15	0	0	0	0	0	0	0	9.84	0	0	11.6	0.1	1.1
2025	11	7	20	32	15	0	0	0	0	0	0	0	9.82	0	0	11.6	0.1	1.1
2025	11	7	20	42	15	0	0	0	0	0	0	0	9.8	0	0	11.6	0.1	1.1
2025	11	7	20	52	15	0	0	0	0	0	0	0	9.79	0	0	11.6	0.1	1.1
2025	11	7	21	2	15	0	0	0	0	0	0	0	9.77	0	0	11.6	0.1	1.1
2025	11	7	21	12	15	0	0	0	0	0	0	0	9.75	0	0	11.6	0.1	1.1
2025	11	7	21	22	15	0	0	0	0	0	0	0	9.73	0	0	11.6	0.1	1.1
2025	11	7	21	32	15	0	0	0	0	0	0	0	9.71	0	0	11.6	0.1	1.1
2025	11	7	21	42	15	0	0	0	0	0	0	0	9.69	0	0	11.6	0.1	1.1
2025	11	7	21	52	15	0	0	0	0	0	0	0	9.68	0	0	11.6	0.1	1.1
2025	11	7	22	2	15	0	0	0	0	0	0	0	9.65	0	0	11.6	0.1	1.1
2025	11	7	22	12	15	0	0	0	0	0	0	0	9.64	0	0	11.6	0.1	1.1
2025	11	7	22	22	15	0	0	0	0	0	0	0	9.62	0	0	11.6	0.1	1.1
2025	11	7	22	32	15	0	0	0	0	0	0	0	9.6	0	0	11.6	0.1	1.1
2025	11	7	22	42	15	0	0	0	0	0	0	0	9.58	0	0	11.6	0.1	1.1
2025	11	7	22	52	15	0	0	0	0	0	0	0	9.57	0	0	11.6	0.1	1.1
2025	11	7	23	2	15	0	0	0	0	0	0	0	9.55	0	0	11.6	0.1	1.1
2025	11	7	23	12	15	0	0	0	0	0	0	0	9.54	0	0	11.6	0.1	1.1
2025	11	7	23	22	15	0	0	0	0	0	0	0	9.53	0	0	11.6	0.1	1.1
2025	11	7	23	32	15	0	0	0	0	0	0	0	9.52	0	0	11.6	0.1	1.1
2025	11	7	23	42	15	0	0	0	0	0	0	0	9.5	0	0	11.6	0.1	1.1
2025	11	7	23	52	15	0	0	0	0	0	0	0	9.49	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	8	0	2	15	0	0	0	0	0	0	0	9.48	0	0	11.6	0.1	1.1
2025	11	8	0	12	15	0	0	0	0	0	0	0	9.47	0	0	11.6	0.1	1.1
2025	11	8	0	22	15	0	0	0	0	0	0	0	9.47	0	0	11.6	0.1	1.1
2025	11	8	0	32	15	0	0	0	0	0	0	0	9.46	0	0	11.6	0.1	1.1
2025	11	8	0	42	15	0	0	0	0	0	0	0	9.46	0	0	11.6	0.1	1.1
2025	11	8	0	52	15	0	0	0	0	0	0	0	9.45	0	0	11.6	0.1	1.1
2025	11	8	1	2	15	0	0	0	0	0	0	0	9.44	0	0	11.6	0.1	1.1
2025	11	8	1	12	15	0	0	0	0	0	0	0	9.44	0	0	11.6	0.1	1.1
2025	11	8	1	22	15	0	0	0	0	0	0	0	9.44	0	0	11.6	0.1	1.1
2025	11	8	1	32	15	0	0	0	0	0	0	0	9.44	0	0	11.6	0.1	1.1
2025	11	8	1	42	15	0	0	0	0	0	0	0	9.44	0	0	11.6	0.1	1.1
2025	11	8	1	52	15	0	0	0	0	0	0	0	9.44	0	0	11.6	0.1	1.1
2025	11	8	2	2	15	0	0	0	0	0	0	0	9.45	0	0	11.6	0.1	1.1
2025	11	8	2	12	15	0	0	0	0	0	0	0	9.45	0	0	11.6	0.1	1.1
2025	11	8	2	22	15	0	0	0	0	0	0	0	9.45	0	0	11.6	0.1	1.1
2025	11	8	2	32	15	0	0	0	0	0	0	0	9.46	0	0	11.6	0.1	1.1
2025	11	8	2	42	15	0	0	0	0	0	0	0	9.46	0	0	11.6	0.1	1.1
2025	11	8	2	52	15	0	0	0	0	0	0	0	9.46	0	0	11.6	0.1	1.1
2025	11	8	3	2	15	0	0	0	0	0	0	0	9.47	0	0	11.6	0.1	1.1
2025	11	8	3	12	15	0	0	0	0	0	0	0	9.47	0	0	11.6	0.1	1.1
2025	11	8	3	22	15	0	0	0	0	0	0	0	9.47	0	0	11.6	0.1	1.1
2025	11	8	3	32	15	0	0	0	0	0	0	0	9.48	0	0	11.6	0.1	1.1
2025	11	8	3	42	15	0	0	0	0	0	0	0	9.48	0	0	11.6	0.1	1.1
2025	11	8	3	52	15	0	0	0	0	0	0	0	9.49	0	0	11.6	0.1	1.1
2025	11	8	4	2	15	0	0	0	0	0	0	0	9.5	0	0	11.6	0.1	1.1
2025	11	8	4	12	15	0	0	0	0	0	0	0	9.5	0	0	11.6	0.1	1.1
2025	11	8	4	22	15	0	0	0	0	0	0	0	9.51	0	0	11.6	0.1	1.1
2025	11	8	4	32	15	0	0	0	0	0	0	0	9.51	0	0	11.6	0.1	1.1
2025	11	8	4	42	15	0	0	0	0	0	0	0	9.52	0	0	11.6	0.1	1.1
2025	11	8	4	52	15	0	0	0	0	0	0	0	9.53	0	0	11.6	0.1	1.1
2025	11	8	5	2	15	0	0	0	0	0	0	0	9.53	0	0	11.4	0.1	1.1
2025	11	8	5	12	15	0	0	0	0	0	0	0	9.54	0	0	11.4	0.1	1.1
2025	11	8	5	22	15	0	0	0	0	0	0	0	9.55	0	0	11.4	0.1	1.1
2025	11	8	5	32	15	0	0	0	0	0	0	0	9.55	0	0	11.4	0.1	1.1
2025	11	8	5	42	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	8	5	52	15	0	0	0	0	0	0	0	9.57	0	0	11.4	0.1	1.1
2025	11	8	6	2	15	0	0	0	0	0	0	0	9.58	0	0	11.4	0.1	1.1
2025	11	8	6	12	15	0	0	0	0	0	0	0	9.58	0	0	11.4	0.1	1.1
2025	11	8	6	22	15	0	0	0	0	0	0	0	9.58	0	0	11.4	0.1	1.1
2025	11	8	6	32	15	0	0	0	0	0	0	0	9.59	0	0	11.4	0.1	1.1
2025	11	8	6	42	15	0	0	0	0	0	0	0	9.6	0	0	11.4	0.1	1.1
2025	11	8	6	52	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1.1
2025	11	8	7	2	15	0	0	0	0	0	0	0	9.62	0	0	11.4	0.1	1.1
2025	11	8	7	12	15	0	0	0	0	0	0	0	9.62	0	0	11.4	0.1	1.1
2025	11	8	7	22	15	0	0	0	0	0	0	0	9.63	0	0	11.4	0.1	1.1
2025	11	8	7	32	15	0	0	0	0	0	0	0	9.63	0	0	11.4	0.1	1.1
2025	11	8	7	42	15	0	0	0	0	0	0	0	9.64	0	0	11.4	0.1	1.1
2025	11	8	7	52	15	0	0	0	0	0	0	0	9.64	0	0	11.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	8	8	2	15	0	0	0	0	0	0	0	9.65	0	0	11.6	0.1	1.1
2025	11	8	8	12	15	0	0	0	0	0	0	0	9.65	0	0	12	0.1	1.1
2025	11	8	8	22	15	0	0	0	0	0	0	0	9.66	0	0	12.2	0.1	1.1
2025	11	8	8	32	15	0	0	0	0	0	0	0	9.68	0	0	12.4	0.1	1.1
2025	11	8	8	42	15	0	0	0	0	0	0	0	9.7	0	0	12.4	0.1	1.1
2025	11	8	8	52	15	0	0	0	0	0	0	0	9.72	0	0	12.6	0.1	1.1
2025	11	8	9	2	15	0	0	0	0	0	0	0	9.75	0	0	12.6	0.1	1.1
2025	11	8	9	12	15	0	0	0	0	0	0	0	9.79	0	0	12.6	0.1	1.1
2025	11	8	9	22	15	0	0	0	0	0	0	0	9.83	0	0	12.6	0.1	1.1
2025	11	8	9	32	15	0	0	0	0	0	0	0	9.86	0	0	12.8	0.1	1.1
2025	11	8	9	42	15	0	0	0	0	0	0	0	9.9	0	0	12.8	0.1	1.1
2025	11	8	9	52	15	0	0	0	0	0	0	0	9.94	0	0	12.8	0.1	1.1
2025	11	8	10	2	15	0	0	0	0	0	0	0	9.97	0	0	12.8	0.1	1.1
2025	11	8	10	12	15	0	0	0	0	0	0	0	9.98	0	0	13	0.1	1.1
2025	11	8	10	22	15	0	0	0	0	0	0	0	10.03	0	0	13	0.1	1.1
2025	11	8	10	32	15	0	0	0	0	0	0	0	10.05	0	0	13.2	0.1	1.1
2025	11	8	10	42	15	0	0	0	0	0	0	0	10.08	0	0	13.8	0.1	1.1
2025	11	8	10	52	15	0	0	0	0	0	0	0	10.1	0	0	13.8	0.1	1.1
2025	11	8	11	2	15	0	0	0	0	0	0	0	10.14	0	0	13.8	0.1	1.1
2025	11	8	11	12	15	0	0	0	0	0	0	0	10.16	0	0	13.8	0.1	1.1
2025	11	8	11	22	15	0	0	0	0	0	0	0	10.19	0	0	13.8	0.1	1.1
2025	11	8	11	32	15	0	0	0	0	0	0	0	10.19	0	0	13.8	0.1	1.1
2025	11	8	11	42	15	0	0	0	0	0	0	0	10.22	0	0	13.8	0.1	1.1
2025	11	8	11	52	15	0	0	0	0	0	0	0	10.24	0	0	13.8	0.1	1.1
2025	11	8	12	2	15	0	0	0	0	0	0	0	10.26	0	0	13.8	0.1	1.1
2025	11	8	12	12	15	0	0	0	0	0	0	0	10.28	0	0	13.8	0.1	1.1
2025	11	8	12	22	15	0	0	0	0	0	0	0	10.3	0	0	13.6	0.1	1.1
2025	11	8	12	32	15	0	0	0	0	0	0	0	10.31	0	0	13.6	0.1	1.1
2025	11	8	12	42	15	0	0	0	0	0	0	0	10.33	0	0	13.6	0.1	1.1
2025	11	8	12	52	15	0	0	0	0	0	0	0	10.34	0	0	13.2	0.1	1.1
2025	11	8	13	2	15	0	0	0	0	0	0	0	10.35	0	0	12.8	0.1	1.1
2025	11	8	13	12	15	0	0	0	0	0	0	0	10.37	0	0	12.8	0.1	1.1
2025	11	8	13	22	15	0	0	0	0	0	0	0	10.37	0	0	12.6	0.1	1.1
2025	11	8	13	32	15	0	0	0	0	0	0	0	10.37	0	0	12.6	0.1	1.1
2025	11	8	13	42	15	0	0	0	0	0	0	0	10.38	0	0	12.6	0.1	1.1
2025	11	8	13	52	15	0	0	0	0	0	0	0	10.4	0	0	12.6	0.1	1.1
2025	11	8	14	2	15	0	0	0	0	0	0	0	10.39	0	0	12.6	0.1	1.1
2025	11	8	14	12	15	0	0	0	0	0	0	0	10.4	0	0	12.8	0.1	1.1
2025	11	8	14	22	15	0	0	0	0	0	0	0	10.39	0	0	12.8	0.1	1.1
2025	11	8	14	32	15	0	0	0	0	0	0	0	10.39	0	0	12.4	0.1	1.1
2025	11	8	14	42	15	0	0	0	0	0	0	0	10.39	0	0	12.4	0.1	1.1
2025	11	8	14	52	15	0	0	0	0	0	0	0	10.38	0	0	12.4	0.1	1.1
2025	11	8	15	2	15	0	0	0	0	0	0	0	10.38	0	0	12.4	0.1	1.1
2025	11	8	15	12	15	0	0	0	0	0	0	0	10.37	0	0	12.4	0.1	1.1
2025	11	8	15	22	15	0	0	0	0	0	0	0	10.35	0	0	12.4	0.1	1.1
2025	11	8	15	32	15	0	0	0	0	0	0	0	10.34	0	0	12.4	0.1	1.1
2025	11	8	15	42	15	0	0	0	0	0	0	0	10.32	0	0	12.4	0.1	1.1
2025	11	8	15	52	15	0	0	0	0	0	0	0	10.27	0	0	12.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	8	16	2	15	0	0	0	0	0	0	0	10.27	0	0	12.4	0.1	1.1
2025	11	8	16	12	15	0	0	0	0	0	0	0	10.24	0	0	12.2	0.1	1.1
2025	11	8	16	22	15	0	0	0	0	0	0	0	10.24	0	0	11.8	0.1	1.1
2025	11	8	16	32	15	0	0	0	0	0	0	0	10.24	0	0	11.6	0.1	1.1
2025	11	8	16	42	15	0	0	0	0	0	0	0	10.23	0	0	11.4	0.1	1.1
2025	11	8	16	52	15	0	0	0	0	0	0	0	10.23	0	0	11.2	0.1	1.1
2025	11	8	17	2	15	0	0	0	0	0	0	0	10.23	0	0	11	0.1	1.1
2025	11	8	17	12	15	0	0	0	0	0	0	0	10.21	0	0	11	0.1	1.1
2025	11	8	17	22	15	0	0	0	0	0	0	0	10.21	0	0	10.8	0.1	1.1
2025	11	8	17	32	15	0	0	0	0	0	0	0	10.2	0	0	10.8	0.1	1.1
2025	11	8	17	42	15	0	0	0	0	0	0	0	10.19	0	0	10.8	0.1	1.1
2025	11	8	17	52	15	0	0	0	0	0	0	0	10.19	0	0	10.8	0.1	1.1
2025	11	8	18	2	15	0	0	0	0	0	0	0	10.17	0	0	10.8	0.1	1.1
2025	11	8	18	12	15	0	0	0	0	0	0	0	10.16	0	0	10.8	0.1	1.1
2025	11	8	18	22	15	0	0	0	0	0	0	0	10.15	0	0	10.8	0.1	1.1
2025	11	8	18	32	15	0	0	0	0	0	0	0	10.14	0	0	10.8	0.1	1.1
2025	11	8	18	42	15	0	0	0	0	0	0	0	10.12	0	0	10.8	0.1	1.1
2025	11	8	18	52	15	0	0	0	0	0	0	0	10.1	0	0	10.8	0.1	1.1
2025	11	8	19	2	15	0	0	0	0	0	0	0	10.09	0	0	10.8	0.1	1.1
2025	11	8	19	12	15	0	0	0	0	0	0	0	10.07	0	0	10.8	0.1	1.1
2025	11	8	19	22	15	0	0	0	0	0	0	0	10.05	0	0	10.8	0.1	1.1
2025	11	8	19	32	15	0	0	0	0	0	0	0	10.03	0	0	10.8	0.1	1.1
2025	11	8	19	42	15	0	0	0	0	0	0	0	10.01	0	0	11.6	0.1	1.1
2025	11	8	19	52	15	0	0	0	0	0	0	0	9.99	0	0	11.6	0.1	1.1
2025	11	8	20	2	15	0	0	0	0	0	0	0	9.97	0	0	11.6	0.1	1.1
2025	11	8	20	12	15	0	0	0	0	0	0	0	9.95	0	0	11.6	0.1	1.1
2025	11	8	20	22	15	0	0	0	0	0	0	0	9.93	0	0	11.6	0.1	1.1
2025	11	8	20	32	15	0	0	0	0	0	0	0	9.91	0	0	11.6	0.1	1.1
2025	11	8	20	42	15	0	0	0	0	0	0	0	9.9	0	0	11.6	0.1	1.1
2025	11	8	20	52	15	0	0	0	0	0	0	0	9.88	0	0	11.6	0.1	1.1
2025	11	8	21	2	15	0	0	0	0	0	0	0	9.86	0	0	11.6	0.1	1.1
2025	11	8	21	12	15	0	0	0	0	0	0	0	9.84	0	0	11.6	0.1	1.1
2025	11	8	21	22	15	0	0	0	0	0	0	0	9.83	0	0	11.6	0.1	1.1
2025	11	8	21	32	15	0	0	0	0	0	0	0	9.81	0	0	11.6	0.1	1.1
2025	11	8	21	42	15	0	0	0	0	0	0	0	9.79	0	0	11.6	0.1	1.1
2025	11	8	21	52	15	0	0	0	0	0	0	0	9.78	0	0	11.6	0.1	1.1
2025	11	8	22	2	15	0	0	0	0	0	0	0	9.76	0	0	11.6	0.1	1.1
2025	11	8	22	12	15	0	0	0	0	0	0	0	9.74	0	0	11.6	0.1	1.1
2025	11	8	22	22	15	0	0	0	0	0	0	0	9.73	0	0	11.6	0.1	1.1
2025	11	8	22	32	15	0	0	0	0	0	0	0	9.72	0	0	11.6	0.1	1.1
2025	11	8	22	42	15	0	0	0	0	0	0	0	9.7	0	0	11.6	0.1	1.1
2025	11	8	22	52	15	0	0	0	0	0	0	0	9.69	0	0	11.6	0.1	1.1
2025	11	8	23	2	15	0	0	0	0	0	0	0	9.68	0	0	11.6	0.1	1.1
2025	11	8	23	12	15	0	0	0	0	0	0	0	9.67	0	0	11.6	0.1	1.1
2025	11	8	23	22	15	0	0	0	0	0	0	0	9.66	0	0	11.6	0.1	1.1
2025	11	8	23	32	15	0	0	0	0	0	0	0	9.64	0	0	11.6	0.1	1.1
2025	11	8	23	42	15	0	0	0	0	0	0	0	9.63	0	0	11.6	0.1	1.1
2025	11	8	23	52	15	0	0	0	0	0	0	0	9.62	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	9	0	2	15	0	0	0	0	0	0	0	9.62	0	0	11.6	0.1	1.1
2025	11	9	0	12	15	0	0	0	0	0	0	0	9.61	0	0	11.6	0.1	1.1
2025	11	9	0	22	15	0	0	0	0	0	0	0	9.6	0	0	11.6	0.1	1.1
2025	11	9	0	32	15	0	0	0	0	0	0	0	9.59	0	0	11.6	0.1	1.1
2025	11	9	0	42	15	0	0	0	0	0	0	0	9.58	0	0	11.6	0.1	1.1
2025	11	9	0	52	15	0	0	0	0	0	0	0	9.58	0	0	11.6	0.1	1.1
2025	11	9	1	2	15	0	0	0	0	0	0	0	9.58	0	0	11.6	0.1	1.1
2025	11	9	1	12	15	0	0	0	0	0	0	0	9.58	0	0	11.6	0.1	1.1
2025	11	9	1	22	15	0	0	0	0	0	0	0	9.57	0	0	11.6	0.1	1.1
2025	11	9	1	32	15	0	0	0	0	0	0	0	9.57	0	0	11.6	0.1	1.1
2025	11	9	1	42	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1.1
2025	11	9	1	52	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1.1
2025	11	9	2	2	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1.1
2025	11	9	2	12	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1.1
2025	11	9	2	22	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1.1
2025	11	9	2	32	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1.1
2025	11	9	2	42	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1.1
2025	11	9	2	52	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1.1
2025	11	9	3	2	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1.1
2025	11	9	3	12	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1.1
2025	11	9	3	22	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1.1
2025	11	9	3	32	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1.1
2025	11	9	3	42	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1.1
2025	11	9	3	52	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1.1
2025	11	9	4	2	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1.1
2025	11	9	4	12	15	0	0	0	0	0	0	0	9.56	0	0	11.6	0.1	1.1
2025	11	9	4	22	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	4	32	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	4	42	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	4	52	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	5	2	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	5	12	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	5	22	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	5	32	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	5	42	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	5	52	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	6	2	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	6	12	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	6	22	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	6	32	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	6	42	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	6	52	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	7	2	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	7	12	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	7	22	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	7	32	15	0	0	0	0	0	0	0	9.55	0	0	11.4	0.1	1.1
2025	11	9	7	42	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	9	7	52	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	9	8	2	15	0	0	0	0	0	0	0	9.55	0	0	11.6	0.1	1.1
2025	11	9	8	12	15	0	0	0	0	0	0	0	9.56	0	0	12	0.1	1.1
2025	11	9	8	22	15	0	0	0	0	0	0	0	9.56	0	0	12.2	0.1	1.1
2025	11	9	8	32	15	0	0	0	0	0	0	0	9.57	0	0	12.4	0.1	1.1
2025	11	9	8	42	15	0	0	0	0	0	0	0	9.57	0	0	12.6	0.1	1.1
2025	11	9	8	52	15	0	0	0	0	0	0	0	9.59	0	0	12.6	0.1	1.1
2025	11	9	9	2	15	0	0	0	0	0	0	0	9.61	0	0	12.6	0.1	1.1
2025	11	9	9	12	15	0	0	0	0	0	0	0	9.63	0	0	12.6	0.1	1.1
2025	11	9	9	22	15	0	0	0	0	0	0	0	9.66	0	0	12.8	0.1	1.1
2025	11	9	9	32	15	0	0	0	0	0	0	0	9.68	0	0	12.8	0.1	1.1
2025	11	9	9	42	15	0	0	0	0	0	0	0	9.7	0	0	12.8	0.1	1.1
2025	11	9	9	52	15	0	0	0	0	0	0	0	9.73	0	0	12.8	0.1	1.1
2025	11	9	10	2	15	0	0	0	0	0	0	0	9.76	0	0	13	0.1	1.1
2025	11	9	10	12	15	0	0	0	0	0	0	0	9.77	0	0	13	0.1	1.1
2025	11	9	10	22	15	0	0	0	0	0	0	0	9.8	0	0	13.2	0.1	1.1
2025	11	9	10	32	15	0	0	0	0	0	0	0	9.81	0	0	13.6	0.1	1.1
2025	11	9	10	42	15	0	0	0	0	0	0	0	9.83	0	0	13.8	0.1	1.1
2025	11	9	10	52	15	0	0	0	0	0	0	0	9.85	0	0	13.8	0.1	1.1
2025	11	9	11	2	15	0	0	0	0	0	0	0	9.88	0	0	13.8	0.1	1.1
2025	11	9	11	12	15	0	0	0	0	0	0	0	9.89	0	0	13.6	0.1	1.1
2025	11	9	11	22	15	0	0	0	0	0	0	0	9.91	0	0	13.6	0.1	1.1
2025	11	9	11	32	15	0	0	0	0	0	0	0	9.93	0	0	13.6	0.1	1.1
2025	11	9	11	42	15	0	0	0	0	0	0	0	9.95	0	0	13.6	0.1	1.1
2025	11	9	11	52	15	0	0	0	0	0	0	0	9.96	0	0	13.6	0.1	1.1
2025	11	9	12	2	15	0	0	0	0	0	0	0	9.98	0	0	13.6	0.1	1.1
2025	11	9	12	12	15	0	0	0	0	0	0	0	9.99	0	0	13.6	0.1	1.1
2025	11	9	12	22	15	0	0	0	0	0	0	0	10.01	0	0	13.6	0.1	1.1
2025	11	9	12	32	15	0	0	0	0	0	0	0	10.02	0	0	13.6	0.1	1.1
2025	11	9	12	42	15	0	0	0	0	0	0	0	10.04	0	0	13.6	0.1	1.1
2025	11	9	12	52	15	0	0	0	0	0	0	0	10.04	0	0	13.4	0.1	1.1
2025	11	9	13	2	15	0	0	0	0	0	0	0	10.05	0	0	13.4	0.1	1.1
2025	11	9	13	12	15	0	0	0	0	0	0	0	10.06	0	0	13.2	0.1	1.1
2025	11	9	13	22	15	0	0	0	0	0	0	0	10.07	0	0	13.2	0.1	1.1
2025	11	9	13	32	15	0	0	0	0	0	0	0	10.08	0	0	13.2	0.1	1.1
2025	11	9	13	42	15	0	0	0	0	0	0	0	10.08	0	0	13.4	0.1	1.1
2025	11	9	13	52	15	0	0	0	0	0	0	0	10.09	0	0	13.4	0.1	1.1
2025	11	9	14	2	15	0	0	0	0	0	0	0	10.09	0	0	13.2	0.1	1.1
2025	11	9	14	12	15	0	0	0	0	0	0	0	10.1	0	0	13	0.1	1.1
2025	11	9	14	22	15	0	0	0	0	0	0	0	10.1	0	0	12.6	0.1	1.1
2025	11	9	14	32	15	0	0	0	0	0	0	0	10.11	0	0	12.6	0.1	1.1
2025	11	9	14	42	15	0	0	0	0	0	0	0	10.1	0	0	12.6	0.1	1.1
2025	11	9	14	52	15	0	0	0	0	0	0	0	10.2	0	0	12.6	0.1	1.1
2025	11	9	15	2	15	0	0	0	0	0	0	0	10.18	0	0	12.6	0.1	1.1
2025	11	9	15	12	15	0	0	0	0	0	0	0	10.17	0	0	12.6	0.1	1.1
2025	11	9	15	22	15	0	0	0	0	0	0	0	10.17	0	0	12.6	0.1	1.1
2025	11	9	15	32	15	0	0	0	0	0	0	0	10.16	0	0	13.2	0.1	1.1
2025	11	9	15	42	15	0	0	0	0	0	0	0	10.13	0	0	13.4	0.1	1.1
2025	11	9	15	52	15	0	0	0	0	0	0	0	10.07	0	0	13	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	9	16	2	15	0	0	0	0	0	0	0	10.07	0	0	13	0.1	1.1
2025	11	9	16	12	15	0	0	0	0	0	0	0	10.04	0	0	12.4	0.1	1.1
2025	11	9	16	22	15	0	0	0	0	0	0	0	10.03	0	0	11.8	0.1	1.1
2025	11	9	16	32	15	0	0	0	0	0	0	0	10.02	0	0	11.6	0.1	1.1
2025	11	9	16	42	15	0	0	0	0	0	0	0	10.02	0	0	11.4	0.1	1.1
2025	11	9	16	52	15	0	0	0	0	0	0	0	10.01	0	0	11.2	0.1	1.1
2025	11	9	17	2	15	0	0	0	0	0	0	0	10.01	0	0	11	0.1	1.1
2025	11	9	17	12	15	0	0	0	0	0	0	0	10	0	0	11.8	0.1	1.1
2025	11	9	17	22	15	0	0	0	0	0	0	0	9.99	0	0	11.8	0.1	1.1
2025	11	9	17	32	15	0	0	0	0	0	0	0	9.97	0	0	11.8	0.1	1.1
2025	11	9	17	42	15	0	0	0	0	0	0	0	9.97	0	0	11.8	0.1	1.1
2025	11	9	17	52	15	0	0	0	0	0	0	0	9.96	0	0	11.8	0.1	1.1
2025	11	9	18	2	15	0	0	0	0	0	0	0	9.94	0	0	11.8	0.1	1.1
2025	11	9	18	12	15	0	0	0	0	0	0	0	9.92	0	0	11.8	0.1	1.1
2025	11	9	18	22	15	0	0	0	0	0	0	0	9.9	0	0	11.8	0.1	1.1
2025	11	9	18	32	15	0	0	0	0	0	0	0	9.89	0	0	11.4	0.1	1.1
2025	11	9	18	42	15	0	0	0	0	0	0	0	9.87	0	0	11.4	0.1	1.1
2025	11	9	18	52	15	0	0	0	0	0	0	0	9.85	0	0	11.2	0.1	1.1
2025	11	9	19	2	15	0	0	0	0	0	0	0	9.83	0	0	11.4	0.1	1.1
2025	11	9	19	12	15	0	0	0	0	0	0	0	9.8	0	0	11.4	0.1	1.1
2025	11	9	19	22	15	0	0	0	0	0	0	0	9.78	0	0	11.4	0.1	1.1
2025	11	9	19	32	15	0	0	0	0	0	0	0	9.76	0	0	11.2	0.1	1.1
2025	11	9	19	42	15	0	0	0	0	0	0	0	9.74	0	0	11.6	0.1	1.1
2025	11	9	19	52	15	0	0	0	0	0	0	0	9.72	0	0	11.6	0.1	1.1
2025	11	9	20	2	15	0	0	0	0	0	0	0	9.7	0	0	11.6	0.1	1.1
2025	11	9	20	12	15	0	0	0	0	0	0	0	9.67	0	0	11.6	0.1	1.1
2025	11	9	20	22	15	0	0	0	0	0	0	0	9.65	0	0	11.6	0.1	1.1
2025	11	9	20	32	15	0	0	0	0	0	0	0	9.62	0	0	11.6	0.1	1.1
2025	11	9	20	42	15	0	0	0	0	0	0	0	9.6	0	0	11.6	0.1	1.1
2025	11	9	20	52	15	0	0	0	0	0	0	0	9.57	0	0	11.6	0.1	1.1
2025	11	9	21	2	15	0	0	0	0	0	0	0	9.55	0	0	11.6	0.1	1.1
2025	11	9	21	12	15	0	0	0	0	0	0	0	9.54	0	0	11.6	0.1	1.1
2025	11	9	21	22	15	0	0	0	0	0	0	0	9.51	0	0	11.6	0.1	1.1
2025	11	9	21	32	15	0	0	0	0	0	0	0	9.49	0	0	11.6	0.1	1.1
2025	11	9	21	42	15	0	0	0	0	0	0	0	9.48	0	0	11.6	0.1	1.1
2025	11	9	21	52	15	0	0	0	0	0	0	0	9.45	0	0	11.6	0.1	1.1
2025	11	9	22	2	15	0	0	0	0	0	0	0	9.43	0	0	11.6	0.1	1.1
2025	11	9	22	12	15	0	0	0	0	0	0	0	9.41	0	0	11.6	0.1	1.1
2025	11	9	22	22	15	0	0	0	0	0	0	0	9.4	0	0	11.6	0.1	1.1
2025	11	9	22	32	15	0	0	0	0	0	0	0	9.38	0	0	11.6	0.1	1.1
2025	11	9	22	42	15	0	0	0	0	0	0	0	9.36	0	0	11.6	0.1	1.1
2025	11	9	22	52	15	0	0	0	0	0	0	0	9.34	0	0	11.6	0.1	1.1
2025	11	9	23	2	15	0	0	0	0	0	0	0	9.33	0	0	11.6	0.1	1.1
2025	11	9	23	12	15	0	0	0	0	0	0	0	9.31	0	0	11.6	0.1	1.1
2025	11	9	23	22	15	0	0	0	0	0	0	0	9.3	0	0	11.6	0.1	1.1
2025	11	9	23	32	15	0	0	0	0	0	0	0	9.29	0	0	11.6	0.1	1.1
2025	11	9	23	42	15	0	0	0	0	0	0	0	9.27	0	0	11.6	0.1	1.1
2025	11	9	23	52	15	0	0	0	0	0	0	0	9.26	0	0	11.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	10	0	2	15	0	0	0	0	0	0	0	9.25	0	0	11.4	0.1	1.1
2025	11	10	0	12	15	0	0	0	0	0	0	0	9.24	0	0	11.4	0.1	1.1
2025	11	10	0	22	15	0	0	0	0	0	0	0	9.23	0	0	11.4	0.1	1.1
2025	11	10	0	32	15	0	0	0	0	0	0	0	9.23	0	0	11.4	0.1	1.1
2025	11	10	0	42	15	0	0	0	0	0	0	0	9.22	0	0	11.4	0.1	1.1
2025	11	10	0	52	15	0	0	0	0	0	0	0	9.22	0	0	11.4	0.1	1.1
2025	11	10	1	2	15	0	0	0	0	0	0	0	9.21	0	0	11.4	0.1	1.1
2025	11	10	1	12	15	0	0	0	0	0	0	0	9.21	0	0	11.4	0.1	1.1
2025	11	10	1	22	15	0	0	0	0	0	0	0	9.2	0	0	11.4	0.1	1.1
2025	11	10	1	32	15	0	0	0	0	0	0	0	9.2	0	0	11.4	0.1	1.1
2025	11	10	1	42	15	0	0	0	0	0	0	0	9.2	0	0	11.4	0.1	1.1
2025	11	10	1	52	15	0	0	0	0	0	0	0	9.2	0	0	11.4	0.1	1.1
2025	11	10	2	2	15	0	0	0	0	0	0	0	9.2	0	0	11.4	0.1	1.1
2025	11	10	2	12	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	2	22	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	2	32	15	0	0	0	0	0	0	0	9.2	0	0	11.4	0.1	1.1
2025	11	10	2	42	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	2	52	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	3	2	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	3	12	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	3	22	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	3	32	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	3	42	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	3	52	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	4	2	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	4	12	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	4	22	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	4	32	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	4	42	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	4	52	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	5	2	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	5	12	15	0	0	0	0	0	0	0	9.2	0	0	11.4	0.1	1.1
2025	11	10	5	22	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	5	32	15	0	0	0	0	0	0	0	9.2	0	0	11.4	0.1	1.1
2025	11	10	5	42	15	0	0	0	0	0	0	0	9.2	0	0	11.4	0.1	1.1
2025	11	10	5	52	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	6	2	15	0	0	0	0	0	0	0	9.2	0	0	11.4	0.1	1.1
2025	11	10	6	12	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	6	22	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	6	32	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	6	42	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	6	52	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	7	2	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	7	12	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	7	22	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	7	32	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	10	7	42	15	0	0	0	0	0	0	0	9.18	0	0	11.4	0.1	1.1
2025	11	10	7	52	15	0	0	0	0	0	0	0	9.18	0	0	11.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	10	8	2	15	0	0	0	0	0	0	0	9.18	0	0	11.6	0.1	1.1
2025	11	10	8	12	15	0	0	0	0	0	0	0	9.18	0	0	11.8	0.1	1.1
2025	11	10	8	22	15	0	0	0	0	0	0	0	9.18	0	0	12	0.1	1.1
2025	11	10	8	32	15	0	0	0	0	0	0	0	9.19	0	0	12.4	0.1	1.1
2025	11	10	8	42	15	0	0	0	0	0	0	0	9.2	0	0	12.4	0.1	1.1
2025	11	10	8	52	15	0	0	0	0	0	0	0	9.2	0	0	12.6	0.1	1.1
2025	11	10	9	2	15	0	0	0	0	0	0	0	9.22	0	0	12.6	0.1	1.1
2025	11	10	9	12	15	0	0	0	0	0	0	0	9.24	0	0	12.6	0.1	1.1
2025	11	10	9	22	15	0	0	0	0	0	0	0	9.26	0	0	12.6	0.1	1.1
2025	11	10	9	32	15	0	0	0	0	0	0	0	9.28	0	0	12.8	0.1	1.1
2025	11	10	9	42	15	0	0	0	0	0	0	0	9.3	0	0	12.8	0.1	1.1
2025	11	10	9	52	15	0	0	0	0	0	0	0	9.32	0	0	12.8	0.1	1.1
2025	11	10	10	2	15	0	0	0	0	0	0	0	9.34	0	0	12.8	0.1	1.1
2025	11	10	10	12	15	0	0	0	0	0	0	0	9.36	0	0	13	0.1	1.1
2025	11	10	10	22	15	0	0	0	0	0	0	0	9.38	0	0	13.2	0.1	1.1
2025	11	10	10	32	15	0	0	0	0	0	0	0	9.41	0	0	13.6	0.1	1.1
2025	11	10	10	42	15	0	0	0	0	0	0	0	9.42	0	0	13.8	0.1	1.1
2025	11	10	10	52	15	0	0	0	0	0	0	0	9.45	0	0	13.8	0.1	1.1
2025	11	10	11	2	15	0	0	0	0	0	0	0	9.47	0	0	13.8	0.1	1.1
2025	11	10	11	12	15	0	0	0	0	0	0	0	9.49	0	0	13.8	0.1	1.1
2025	11	10	11	22	15	0	0	0	0	0	0	0	9.5	0	0	13.8	0.1	1.1
2025	11	10	11	32	15	0	0	0	0	0	0	0	9.5	0	0	13.6	0.1	1.1
2025	11	10	11	42	15	0	0	0	0	0	0	0	9.53	0	0	13.6	0.1	1.1
2025	11	10	11	52	15	0	0	0	0	0	0	0	9.54	0	0	13.6	0.1	1.1
2025	11	10	12	2	15	0	0	0	0	0	0	0	9.57	0	0	13.6	0.1	1.1
2025	11	10	12	12	15	0	0	0	0	0	0	0	9.59	0	0	13.6	0.1	1.1
2025	11	10	12	22	15	0	0	0	0	0	0	0	9.61	0	0	13.6	0.1	1.1
2025	11	10	12	32	15	0	0	0	0	0	0	0	9.62	0	0	13.4	0.1	1.1
2025	11	10	12	42	15	0	0	0	0	0	0	0	9.63	0	0	13.4	0.1	1.1
2025	11	10	12	52	15	0	0	0	0	0	0	0	9.65	0	0	13.2	0.1	1.1
2025	11	10	13	2	15	0	0	0	0	0	0	0	9.66	0	0	13	0.1	1.1
2025	11	10	13	12	15	0	0	0	0	0	0	0	9.68	0	0	13	0.1	1.1
2025	11	10	13	22	15	0	0	0	0	0	0	0	9.67	0	0	12.6	0.1	1.1
2025	11	10	13	32	15	0	0	0	0	0	0	0	9.69	0	0	12.4	0.1	1.1
2025	11	10	13	42	15	0	0	0	0	0	0	0	9.71	0	0	12.4	0.1	1.1
2025	11	10	13	52	15	0	0	0	0	0	0	0	9.73	0	0	12.6	0.1	1.1
2025	11	10	14	2	15	0	0	0	0	0	0	0	9.72	0	0	12.6	0.1	1.1
2025	11	10	14	12	15	0	0	0	0	0	0	0	9.73	0	0	12.6	0.1	1.1
2025	11	10	14	22	15	0	0	0	0	0	0	0	9.72	0	0	12.6	0.1	1.1
2025	11	10	14	32	15	0	0	0	0	0	0	0	9.73	0	0	12.8	0.1	1.1
2025	11	10	14	42	15	0	0	0	0	0	0	0	9.73	0	0	12.8	0.1	1.1
2025	11	10	14	52	15	0	0	0	0	0	0	0	9.74	0	0	12.6	0.1	1.1
2025	11	10	15	2	15	0	0	0	0	0	0	0	9.74	0	0	12.6	0.1	1.1
2025	11	10	15	12	15	0	0	0	0	0	0	0	9.74	0	0	12.6	0.1	1.1
2025	11	10	15	22	15	0	0	0	0	0	0	0	9.75	0	0	12.6	0.1	1.1
2025	11	10	15	32	15	0	0	0	0	0	0	0	9.74	0	0	12.6	0.1	1.1
2025	11	10	15	42	15	0	0	0	0	0	0	0	9.73	0	0	12.6	0.1	1.1
2025	11	10	15	52	15	0	0	0	0	0	0	0	9.71	0	0	12.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	10	16	2	15	0	0	0	0	0	0	0	9.7	0	0	12.6	0.1	1.1
2025	11	10	16	12	15	0	0	0	0	0	0	0	9.7	0	0	12	0.1	1.1
2025	11	10	16	22	15	0	0	0	0	0	0	0	9.69	0	0	11.8	0.1	1.1
2025	11	10	16	32	15	0	0	0	0	0	0	0	9.68	0	0	11.4	0.1	1.1
2025	11	10	16	42	15	0	0	0	0	0	0	0	9.68	0	0	11.2	0.1	1.1
2025	11	10	16	52	15	0	0	0	0	0	0	0	9.68	0	0	11	0.1	1.1
2025	11	10	17	2	15	0	0	0	0	0	0	0	9.68	0	0	10.8	0.1	1.1
2025	11	10	17	12	15	0	0	0	0	0	0	0	9.68	0	0	10.8	0.1	1.1
2025	11	10	17	22	15	0	0	0	0	0	0	0	9.67	0	0	10.8	0.1	1.1
2025	11	10	17	32	15	0	0	0	0	0	0	0	9.66	0	0	11	0.1	1.1
2025	11	10	17	42	15	0	0	0	0	0	0	0	9.66	0	0	11	0.1	1.1
2025	11	10	17	52	15	0	0	0	0	0	0	0	9.65	0	0	11.2	0.1	1.1
2025	11	10	18	2	15	0	0	0	0	0	0	0	9.64	0	0	11	0.1	1.1
2025	11	10	18	12	15	0	0	0	0	0	0	0	9.63	0	0	10.8	0.1	1.1
2025	11	10	18	22	15	0	0	0	0	0	0	0	9.61	0	0	10.8	0.1	1.1
2025	11	10	18	32	15	0	0	0	0	0	0	0	9.59	0	0	10.8	0.1	1.1
2025	11	10	18	42	15	0	0	0	0	0	0	0	9.58	0	0	10.8	0.1	1.1
2025	11	10	18	52	15	0	0	0	0	0	0	0	9.56	0	0	10.8	0.1	1.1
2025	11	10	19	2	15	0	0	0	0	0	0	0	9.54	0	0	10.8	0.1	1.1
2025	11	10	19	12	15	0	0	0	0	0	0	0	9.52	0	0	10.8	0.1	1.1
2025	11	10	19	22	15	0	0	0	0	0	0	0	9.5	0	0	10.8	0.1	1.1
2025	11	10	19	32	15	0	0	0	0	0	0	0	9.48	0	0	10.8	0.1	1.1
2025	11	10	19	42	15	0	0	0	0	0	0	0	9.46	0	0	10.8	0.1	1.1
2025	11	10	19	52	15	0	0	0	0	0	0	0	9.44	0	0	10.8	0.1	1.1
2025	11	10	20	2	15	0	0	0	0	0	0	0	9.42	0	0	10.8	0.1	1.1
2025	11	10	20	12	15	0	0	0	0	0	0	0	9.4	0	0	10.8	0.1	1.1
2025	11	10	20	22	15	0	0	0	0	0	0	0	9.38	0	0	10.8	0.1	1.1
2025	11	10	20	32	15	0	0	0	0	0	0	0	9.36	0	0	10.8	0.1	1.1
2025	11	10	20	42	15	0	0	0	0	0	0	0	9.34	0	0	10.8	0.1	1.1
2025	11	10	20	52	15	0	0	0	0	0	0	0	9.32	0	0	10.8	0.1	1.1
2025	11	10	21	2	15	0	0	0	0	0	0	0	9.3	0	0	10.8	0.1	1.1
2025	11	10	21	12	15	0	0	0	0	0	0	0	9.28	0	0	10.8	0.1	1.1
2025	11	10	21	22	15	0	0	0	0	0	0	0	9.26	0	0	10.8	0.1	1.1
2025	11	10	21	32	15	0	0	0	0	0	0	0	9.24	0	0	10.8	0.1	1.1
2025	11	10	21	42	15	0	0	0	0	0	0	0	9.22	0	0	10.8	0.1	1.1
2025	11	10	21	52	15	0	0	0	0	0	0	0	9.2	0	0	10.8	0.1	1.1
2025	11	10	22	2	15	0	0	0	0	0	0	0	9.18	0	0	10.8	0.1	1.1
2025	11	10	22	12	15	0	0	0	0	0	0	0	9.16	0	0	10.8	0.1	1.1
2025	11	10	22	22	15	0	0	0	0	0	0	0	9.14	0	0	10.8	0.1	1.1
2025	11	10	22	32	15	0	0	0	0	0	0	0	9.12	0	0	10.6	0.1	1.1
2025	11	10	22	42	15	0	0	0	0	0	0	0	9.11	0	0	10.6	0.1	1.1
2025	11	10	22	52	15	0	0	0	0	0	0	0	9.09	0	0	10.6	0.1	1.1
2025	11	10	23	2	15	0	0	0	0	0	0	0	9.08	0	0	10.6	0.1	1.1
2025	11	10	23	12	15	0	0	0	0	0	0	0	9.07	0	0	10.6	0.1	1.1
2025	11	10	23	22	15	0	0	0	0	0	0	0	9.05	0	0	10.6	0.1	1.1
2025	11	10	23	32	15	0	0	0	0	0	0	0	9.04	0	0	10.6	0.1	1.1
2025	11	10	23	42	15	0	0	0	0	0	0	0	9.03	0	0	10.6	0.1	1.1
2025	11	10	23	52	15	0	0	0	0	0	0	0	9.02	0	0	10.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	11	0	2	15	0	0	0	0	0	0	0	9	0	0	10.6	0.1	1.1
2025	11	11	0	12	15	0	0	0	0	0	0	0	8.99	0	0	10.6	0.1	1.1
2025	11	11	0	22	15	0	0	0	0	0	0	0	8.99	0	0	10.6	0.1	1.1
2025	11	11	0	32	15	0	0	0	0	0	0	0	8.98	0	0	10.6	0.1	1.1
2025	11	11	0	42	15	0	0	0	0	0	0	0	8.97	0	0	10.6	0.1	1.1
2025	11	11	0	52	15	0	0	0	0	0	0	0	8.97	0	0	11.2	0.1	1.1
2025	11	11	1	2	15	0	0	0	0	0	0	0	8.96	0	0	11.6	0.1	1.1
2025	11	11	1	12	15	0	0	0	0	0	0	0	8.96	0	0	11.6	0.1	1.1
2025	11	11	1	22	15	0	0	0	0	0	0	0	8.95	0	0	11.6	0.1	1.1
2025	11	11	1	32	15	0	0	0	0	0	0	0	8.95	0	0	11.6	0.1	1.1
2025	11	11	1	42	15	0	0	0	0	0	0	0	8.94	0	0	11.6	0.1	1.1
2025	11	11	1	52	15	0	0	0	0	0	0	0	8.95	0	0	11.6	0.1	1.1
2025	11	11	2	2	15	0	0	0	0	0	0	0	8.95	0	0	11.6	0.1	1.1
2025	11	11	2	12	15	0	0	0	0	0	0	0	8.94	0	0	11.6	0.1	1.1
2025	11	11	2	22	15	0	0	0	0	0	0	0	8.95	0	0	11.6	0.1	1.1
2025	11	11	2	32	15	0	0	0	0	0	0	0	8.95	0	0	11.6	0.1	1.1
2025	11	11	2	42	15	0	0	0	0	0	0	0	8.94	0	0	11.6	0.1	1.1
2025	11	11	2	52	15	0	0	0	0	0	0	0	8.94	0	0	11.6	0.1	1.1
2025	11	11	3	2	15	0	0	0	0	0	0	0	8.95	0	0	11.6	0.1	1.1
2025	11	11	3	12	15	0	0	0	0	0	0	0	8.95	0	0	11.6	0.1	1.1
2025	11	11	3	22	15	0	0	0	0	0	0	0	8.95	0	0	11.6	0.1	1.1
2025	11	11	3	32	15	0	0	0	0	0	0	0	8.95	0	0	11.6	0.1	1.1
2025	11	11	3	42	15	0	0	0	0	0	0	0	8.96	0	0	11.6	0.1	1.1
2025	11	11	3	52	15	0	0	0	0	0	0	0	8.96	0	0	11.6	0.1	1.1
2025	11	11	4	2	15	0	0	0	0	0	0	0	8.97	0	0	11.6	0.1	1.1
2025	11	11	4	12	15	0	0	0	0	0	0	0	8.96	0	0	11.6	0.1	1.1
2025	11	11	4	22	15	0	0	0	0	0	0	0	8.97	0	0	11.4	0.1	1.1
2025	11	11	4	32	15	0	0	0	0	0	0	0	8.97	0	0	11.4	0.1	1.1
2025	11	11	4	42	15	0	0	0	0	0	0	0	8.97	0	0	11.4	0.1	1.1
2025	11	11	4	52	15	0	0	0	0	0	0	0	8.98	0	0	11	0.1	1.1
2025	11	11	5	2	15	0	0	0	0	0	0	0	8.98	0	0	10.6	0.1	1.1
2025	11	11	5	12	15	0	0	0	0	0	0	0	8.98	0	0	10.6	0.1	1.1
2025	11	11	5	22	15	0	0	0	0	0	0	0	8.98	0	0	10.6	0.1	1.1
2025	11	11	5	32	15	0	0	0	0	0	0	0	8.98	0	0	10.8	0.1	1.1
2025	11	11	5	42	15	0	0	0	0	0	0	0	8.99	0	0	10.8	0.1	1.1
2025	11	11	5	52	15	0	0	0	0	0	0	0	8.98	0	0	10.8	0.1	1.1
2025	11	11	6	2	15	0	0	0	0	0	0	0	8.99	0	0	10.8	0.1	1.1
2025	11	11	6	12	15	0	0	0	0	0	0	0	8.99	0	0	10.6	0.1	1.1
2025	11	11	6	22	15	0	0	0	0	0	0	0	8.99	0	0	10.6	0.1	1.1
2025	11	11	6	32	15	0	0	0	0	0	0	0	8.99	0	0	10.6	0.1	1.1
2025	11	11	6	42	15	0	0	0	0	0	0	0	9	0	0	10.6	0.1	1.1
2025	11	11	6	52	15	0	0	0	0	0	0	0	9	0	0	10.6	0.1	1.1
2025	11	11	7	2	15	0	0	0	0	0	0	0	9	0	0	10.6	0.1	1.1
2025	11	11	7	12	15	0	0	0	0	0	0	0	9	0	0	10.6	0.1	1.1
2025	11	11	7	22	15	0	0	0	0	0	0	0	9	0	0	10.6	0.1	1.1
2025	11	11	7	32	15	0	0	0	0	0	0	0	9	0	0	10.6	0.1	1.1
2025	11	11	7	42	15	0	0	0	0	0	0	0	9	0	0	10.6	0.1	1.1
2025	11	11	7	52	15	0	0	0	0	0	0	0	9.01	0	0	10.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	11	8	2	15	0	0	0	0	0	0	0	9.01	0	0	10.6	0.1	1.1
2025	11	11	8	12	15	0	0	0	0	0	0	0	9.02	0	0	10.8	0.1	1.1
2025	11	11	8	22	15	0	0	0	0	0	0	0	9.03	0	0	10.8	0.1	1.1
2025	11	11	8	32	15	0	0	0	0	0	0	0	9.04	0	0	11	0.1	1.1
2025	11	11	8	42	15	0	0	0	0	0	0	0	9.05	0	0	11.2	0.1	1.1
2025	11	11	8	52	15	0	0	0	0	0	0	0	9.06	0	0	11.4	0.1	1.1
2025	11	11	9	2	15	0	0	0	0	0	0	0	9.07	0	0	11.4	0.1	1.1
2025	11	11	9	12	15	0	0	0	0	0	0	0	9.09	0	0	11.6	0.1	1.1
2025	11	11	9	22	15	0	0	0	0	0	0	0	9.11	0	0	11.6	0.1	1.1
2025	11	11	9	32	15	0	0	0	0	0	0	0	9.13	0	0	11.6	0.1	1.1
2025	11	11	9	42	15	0	0	0	0	0	0	0	9.13	0	0	11.6	0.1	1.1
2025	11	11	9	52	15	0	0	0	0	0	0	0	9.15	0	0	11.6	0.1	1.1
2025	11	11	10	2	15	0	0	0	0	0	0	0	9.17	0	0	11.6	0.1	1.1
2025	11	11	10	12	15	0	0	0	0	0	0	0	9.19	0	0	12	0.1	1.1
2025	11	11	10	22	15	0	0	0	0	0	0	0	9.22	0	0	12	0.1	1.1
2025	11	11	10	32	15	0	0	0	0	0	0	0	9.22	0	0	11.6	0.1	1.1
2025	11	11	10	42	15	0	0	0	0	0	0	0	9.2	0	0	11.6	0.1	1.1
2025	11	11	10	52	15	0	0	0	0	0	0	0	9.24	0	0	12.2	0.1	1.1
2025	11	11	11	2	15	0	0	0	0	0	0	0	9.31	0	0	12.4	0.1	1.1
2025	11	11	11	12	15	0	0	0	0	0	0	0	9.34	0	0	12.4	0.1	1.1
2025	11	11	11	22	15	0	0	0	0	0	0	0	9.36	0	0	12.4	0.1	1.1
2025	11	11	11	32	15	0	0	0	0	0	0	0	9.36	0	0	12.2	0.1	1.1
2025	11	11	11	42	15	0	0	0	0	0	0	0	9.36	0	0	13	0.1	1.1
2025	11	11	11	52	15	0	0	0	0	0	0	0	9.42	0	0	13.8	0.1	1.1
2025	11	11	12	2	15	0	0	0	0	0	0	0	9.44	0	0	13.8	0.1	1.1
2025	11	11	12	12	15	0	0	0	0	0	0	0	9.46	0	0	13.6	0.1	1.1
2025	11	11	12	22	15	0	0	0	0	0	0	0	9.43	0	0	13	0.1	1.1
2025	11	11	12	32	15	0	0	0	0	0	0	0	9.44	0	0	13.6	0.1	1.1
2025	11	11	12	42	15	0	0	0	0	0	0	0	9.49	0	0	13.6	0.1	1.1
2025	11	11	12	52	15	0	0	0	0	0	0	0	9.49	0	0	13.6	0.1	1.1
2025	11	11	13	2	15	0	0	0	0	0	0	0	9.48	0	0	13.2	0.1	1.1
2025	11	11	13	12	15	0	0	0	0	0	0	0	9.48	0	0	13.2	0.1	1.1
2025	11	11	13	22	15	0	0	0	0	0	0	0	9.48	0	0	13.4	0.1	1.1
2025	11	11	13	32	15	0	0	0	0	0	0	0	9.48	0	0	12.4	0.1	1.1
2025	11	11	13	42	15	0	0	0	0	0	0	0	9.46	0	0	12.6	0.1	1.1
2025	11	11	13	52	15	0	0	0	0	0	0	0	9.46	0	0	12.4	0.1	1.1
2025	11	11	14	2	15	0	0	0	0	0	0	0	9.46	0	0	12.4	0.1	1.1
2025	11	11	14	12	15	0	0	0	0	0	0	0	9.48	0	0	13.6	0.1	1.1
2025	11	11	14	22	15	0	0	0	0	0	0	0	9.52	0	0	13.8	0.1	1.1
2025	11	11	14	32	15	0	0	0	0	0	0	0	9.56	0	0	13.6	0.1	1.1
2025	11	11	14	42	15	0	0	0	0	0	0	0	9.53	0	0	12.4	0.1	1.1
2025	11	11	14	52	15	0	0	0	0	0	0	0	9.52	0	0	12.2	0.1	1.1
2025	11	11	15	2	15	0	0	0	0	0	0	0	9.52	0	0	12	0.1	1.1
2025	11	11	15	12	15	0	0	0	0	0	0	0	9.52	0	0	11.6	0.1	1.1
2025	11	11	15	22	15	0	0	0	0	0	0	0	9.52	0	0	12	0.1	1.1
2025	11	11	15	32	15	0	0	0	0	0	0	0	9.52	0	0	12.2	0.1	1.1
2025	11	11	15	42	15	0	0	0	0	0	0	0	9.52	0	0	12.2	0.1	1.1
2025	11	11	15	52	15	0	0	0	0	0	0	0	9.52	0	0	11.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	11	16	2	15	0	0	0	0	0	0	0	9.5	0	0	11.2	0.1	1.1
2025	11	11	16	12	15	0	0	0	0	0	0	0	9.5	0	0	11.4	0.1	1.1
2025	11	11	16	22	15	0	0	0	0	0	0	0	9.5	0	0	11.2	0.1	1.1
2025	11	11	16	32	15	0	0	0	0	0	0	0	9.49	0	0	11.6	0.1	1.1
2025	11	11	16	42	15	0	0	0	0	0	0	0	9.48	0	0	11.4	0.1	1.1
2025	11	11	16	52	15	0	0	0	0	0	0	0	9.48	0	0	11.4	0.1	1.1
2025	11	11	17	2	15	0	0	0	0	0	0	0	9.46	0	0	11.4	0.1	1.1
2025	11	11	17	12	15	0	0	0	0	0	0	0	9.46	0	0	11.4	0.1	1.1
2025	11	11	17	22	15	0	0	0	0	0	0	0	9.45	0	0	11.4	0.1	1.1
2025	11	11	17	32	15	0	0	0	0	0	0	0	9.44	0	0	11.4	0.1	1.1
2025	11	11	17	42	15	0	0	0	0	0	0	0	9.43	0	0	11.4	0.1	1.1
2025	11	11	17	52	15	0	0	0	0	0	0	0	9.42	0	0	11.4	0.1	1.1
2025	11	11	18	2	15	0	0	0	0	0	0	0	9.42	0	0	11.4	0.1	1.1
2025	11	11	18	12	15	0	0	0	0	0	0	0	9.41	0	0	11.8	0.1	1.1
2025	11	11	18	22	15	0	0	0	0	0	0	0	9.4	0	0	11.6	0.1	1.1
2025	11	11	18	32	15	0	0	0	0	0	0	0	9.38	0	0	11.4	0.1	1.1
2025	11	11	18	42	15	0	0	0	0	0	0	0	9.37	0	0	11.2	0.1	1.1
2025	11	11	18	52	15	0	0	0	0	0	0	0	9.36	0	0	11.2	0.1	1.1
2025	11	11	19	2	15	0	0	0	0	0	0	0	9.35	0	0	11.2	0.1	1.1
2025	11	11	19	12	15	0	0	0	0	0	0	0	9.34	0	0	11.2	0.1	1.1
2025	11	11	19	22	15	0	0	0	0	0	0	0	9.32	0	0	11.2	0.1	1.1
2025	11	11	19	32	15	0	0	0	0	0	0	0	9.31	0	0	11.2	0.1	1.1
2025	11	11	19	42	15	0	0	0	0	0	0	0	9.29	0	0	11.2	0.1	1.1
2025	11	11	19	52	15	0	0	0	0	0	0	0	9.28	0	0	11.2	0.1	1.1
2025	11	11	20	2	15	0	0	0	0	0	0	0	9.27	0	0	11.2	0.1	1.1
2025	11	11	20	12	15	0	0	0	0	0	0	0	9.25	0	0	11.2	0.1	1.1
2025	11	11	20	22	15	0	0	0	0	0	0	0	9.25	0	0	11.2	0.1	1.1
2025	11	11	20	32	15	0	0	0	0	0	0	0	9.23	0	0	11.2	0.1	1.1
2025	11	11	20	42	15	0	0	0	0	0	0	0	9.22	0	0	11.2	0.1	1.1
2025	11	11	20	52	15	0	0	0	0	0	0	0	9.2	0	0	11.2	0.1	1.1
2025	11	11	21	2	15	0	0	0	0	0	0	0	9.19	0	0	11.2	0.1	1.1
2025	11	11	21	12	15	0	0	0	0	0	0	0	9.17	0	0	11.2	0.1	1.1
2025	11	11	21	22	15	0	0	0	0	0	0	0	9.16	0	0	11.2	0.1	1.1
2025	11	11	21	32	15	0	0	0	0	0	0	0	9.14	0	0	11.2	0.1	1.1
2025	11	11	21	42	15	0	0	0	0	0	0	0	9.13	0	0	11.2	0.1	1.1
2025	11	11	21	52	15	0	0	0	0	0	0	0	9.12	0	0	11.2	0.1	1.1
2025	11	11	22	2	15	0	0	0	0	0	0	0	9.1	0	0	11.2	0.1	1.1
2025	11	11	22	12	15	0	0	0	0	0	0	0	9.09	0	0	11.2	0.1	1.1
2025	11	11	22	22	15	0	0	0	0	0	0	0	9.08	0	0	11.2	0.1	1.1
2025	11	11	22	32	15	0	0	0	0	0	0	0	9.07	0	0	11.2	0.1	1.1
2025	11	11	22	42	15	0	0	0	0	0	0	0	9.06	0	0	11.2	0.1	1.1
2025	11	11	22	52	15	0	0	0	0	0	0	0	9.05	0	0	11.2	0.1	1.1
2025	11	11	23	2	15	0	0	0	0	0	0	0	9.04	0	0	11.2	0.1	1.1
2025	11	11	23	12	15	0	0	0	0	0	0	0	9.03	0	0	11.2	0.1	1.1
2025	11	11	23	22	15	0	0	0	0	0	0	0	9.02	0	0	11.2	0.1	1.1
2025	11	11	23	32	15	0	0	0	0	0	0	0	9	0	0	11.2	0.1	1.1
2025	11	11	23	42	15	0	0	0	0	0	0	0	9	0	0	11.2	0.1	1.1
2025	11	11	23	52	15	0	0	0	0	0	0	0	8.99	0	0	11	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	12	0	2	15	0	0	0	0	0	0	0	8.99	0	0	11	0.1	1.1
2025	11	12	0	12	15	0	0	0	0	0	0	0	8.98	0	0	11	0.1	1.1
2025	11	12	0	22	15	0	0	0	0	0	0	0	8.97	0	0	11	0.1	1.1
2025	11	12	0	32	15	0	0	0	0	0	0	0	8.97	0	0	11	0.1	1.1
2025	11	12	0	42	15	0	0	0	0	0	0	0	8.97	0	0	11	0.1	1.1
2025	11	12	0	52	15	0	0	0	0	0	0	0	8.97	0	0	11	0.1	1.1
2025	11	12	1	2	15	0	0	0	0	0	0	0	8.97	0	0	11	0.1	1.1
2025	11	12	1	12	15	0	0	0	0	0	0	0	8.97	0	0	11	0.1	1.1
2025	11	12	1	22	15	0	0	0	0	0	0	0	8.97	0	0	11	0.1	1.1
2025	11	12	1	32	15	0	0	0	0	0	0	0	8.97	0	0	11	0.1	1.1
2025	11	12	1	42	15	0	0	0	0	0	0	0	8.98	0	0	11	0.1	1.1
2025	11	12	1	52	15	0	0	0	0	0	0	0	8.98	0	0	11	0.1	1.1
2025	11	12	2	2	15	0	0	0	0	0	0	0	8.99	0	0	11	0.1	1.1
2025	11	12	2	12	15	0	0	0	0	0	0	0	8.99	0	0	11	0.1	1.1
2025	11	12	2	22	15	0	0	0	0	0	0	0	8.99	0	0	11.2	0.1	1.1
2025	11	12	2	32	15	0	0	0	0	0	0	0	8.99	0	0	11.2	0.1	1.1
2025	11	12	2	42	15	0	0	0	0	0	0	0	9	0	0	11	0.1	1.1
2025	11	12	2	52	15	0	0	0	0	0	0	0	9	0	0	11.2	0.1	1.1
2025	11	12	3	2	15	0	0	0	0	0	0	0	9.01	0	0	11	0.1	1.1
2025	11	12	3	12	15	0	0	0	0	0	0	0	9.02	0	0	11	0.1	1.1
2025	11	12	3	22	15	0	0	0	0	0	0	0	9.02	0	0	11	0.1	1.1
2025	11	12	3	32	15	0	0	0	0	0	0	0	9.03	0	0	11	0.1	1.1
2025	11	12	3	42	15	0	0	0	0	0	0	0	9.03	0	0	11	0.1	1.1
2025	11	12	3	52	15	0	0	0	0	0	0	0	9.04	0	0	11	0.1	1.1
2025	11	12	4	2	15	0	0	0	0	0	0	0	9.04	0	0	11	0.1	1.1
2025	11	12	4	12	15	0	0	0	0	0	0	0	9.05	0	0	11	0.1	1.1
2025	11	12	4	22	15	0	0	0	0	0	0	0	9.06	0	0	11	0.1	1.1
2025	11	12	4	32	15	0	0	0	0	0	0	0	9.07	0	0	11	0.1	1.1
2025	11	12	4	42	15	0	0	0	0	0	0	0	9.08	0	0	11	0.1	1.1
2025	11	12	4	52	15	0	0	0	0	0	0	0	9.08	0	0	11	0.1	1.1
2025	11	12	5	2	15	0	0	0	0	0	0	0	9.09	0	0	11	0.1	1.1
2025	11	12	5	12	15	0	0	0	0	0	0	0	9.1	0	0	11	0.1	1.1
2025	11	12	5	22	15	0	0	0	0	0	0	0	9.11	0	0	11	0.1	1.1
2025	11	12	5	32	15	0	0	0	0	0	0	0	9.12	0	0	11	0.1	1.1
2025	11	12	5	42	15	0	0	0	0	0	0	0	9.13	0	0	11	0.1	1.1
2025	11	12	5	52	15	0	0	0	0	0	0	0	9.14	0	0	11	0.1	1.1
2025	11	12	6	2	15	0	0	0	0	0	0	0	9.15	0	0	11	0.1	1.1
2025	11	12	6	12	15	0	0	0	0	0	0	0	9.16	0	0	11	0.1	1.1
2025	11	12	6	22	15	0	0	0	0	0	0	0	9.17	0	0	11	0.1	1.1
2025	11	12	6	32	15	0	0	0	0	0	0	0	9.19	0	0	11	0.1	1.1
2025	11	12	6	42	15	0	0	0	0	0	0	0	9.2	0	0	11	0.1	1.1
2025	11	12	6	52	15	0	0	0	0	0	0	0	9.21	0	0	11	0.1	1.1
2025	11	12	7	2	15	0	0	0	0	0	0	0	9.22	0	0	11	0.1	1.1
2025	11	12	7	12	15	0	0	0	0	0	0	0	9.23	0	0	11	0.1	1.1
2025	11	12	7	22	15	0	0	0	0	0	0	0	9.24	0	0	11	0.1	1.1
2025	11	12	7	32	15	0	0	0	0	0	0	0	9.25	0	0	11	0.1	1.1
2025	11	12	7	42	15	0	0	0	0	0	0	0	9.26	0	0	11	0.1	1.1
2025	11	12	7	52	15	0	0	0	0	0	0	0	9.28	0	0	11	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	12	8	2	15	0	0	0	0	0	0	0	9.29	0	0	11.2	0.1	1.1
2025	11	12	8	12	15	0	0	0	0	0	0	0	9.31	0	0	11.2	0.1	1.1
2025	11	12	8	22	15	0	0	0	0	0	0	0	9.32	0	0	11.2	0.1	1.1
2025	11	12	8	32	15	0	0	0	0	0	0	0	9.34	0	0	11	0.1	1.1
2025	11	12	8	42	15	0	0	0	0	0	0	0	9.35	0	0	11	0.1	1.1
2025	11	12	8	52	15	0	0	0	0	0	0	0	9.36	0	0	11	0.1	1.1
2025	11	12	9	2	15	0	0	0	0	0	0	0	9.37	0	0	11	0.1	1.1
2025	11	12	9	12	15	0	0	0	0	0	0	0	9.39	0	0	11.2	0.1	1.1
2025	11	12	9	22	15	0	0	0	0	0	0	0	9.4	0	0	11.2	0.1	1.1
2025	11	12	9	32	15	0	0	0	0	0	0	0	9.42	0	0	11.2	0.1	1.1
2025	11	12	9	42	15	0	0	0	0	0	0	0	9.43	0	0	11.2	0.1	1.1
2025	11	12	9	52	15	0	0	0	0	0	0	0	9.44	0	0	11.2	0.1	1.1
2025	11	12	10	2	15	0	0	0	0	0	0	0	9.45	0	0	11.4	0.1	1.1
2025	11	12	10	12	15	0	0	0	0	0	0	0	9.47	0	0	11.4	0.1	1.1
2025	11	12	10	22	15	0	0	0	0	0	0	0	9.48	0	0	11.4	0.1	1.1
2025	11	12	10	32	15	0	0	0	0	0	0	0	9.49	0	0	11.4	0.1	1.1
2025	11	12	10	42	15	0	0	0	0	0	0	0	9.5	0	0	11.6	0.1	1.1
2025	11	12	10	52	15	0	0	0	0	0	0	0	9.51	0	0	11.8	0.1	1.1
2025	11	12	11	2	15	0	0	0	0	0	0	0	9.52	0	0	11.8	0.1	1.1
2025	11	12	11	12	15	0	0	0	0	0	0	0	9.53	0	0	11.8	0.1	1.1
2025	11	12	11	22	15	0	0	0	0	0	0	0	9.53	0	0	11.8	0.1	1.1
2025	11	12	11	32	15	0	0	0	0	0	0	0	9.54	0	0	11.8	0.1	1.1
2025	11	12	11	42	15	0	0	0	0	0	0	0	9.58	0	0	12.8	0.1	1.1
2025	11	12	11	52	15	0	0	0	0	0	0	0	9.59	0	0	12.6	0.1	1.1
2025	11	12	12	2	15	0	0	0	0	0	0	0	9.57	0	0	11.8	0.1	1.1
2025	11	12	12	12	15	0	0	0	0	0	0	0	9.57	0	0	12	0.1	1.1
2025	11	12	12	22	15	0	0	0	0	0	0	0	9.57	0	0	12.2	0.1	1.1
2025	11	12	12	32	15	0	0	0	0	0	0	0	9.59	0	0	12.2	0.1	1.1
2025	11	12	12	42	15	0	0	0	0	0	0	0	9.62	0	0	12.4	0.1	1.1
2025	11	12	12	52	15	0	0	0	0	0	0	0	9.67	0	0	13.6	0.1	1.1
2025	11	12	13	2	15	0	0	0	0	0	0	0	9.72	0	0	13.6	0.1	1.1
2025	11	12	13	12	15	0	0	0	0	0	0	0	9.73	0	0	14	0.1	1.1
2025	11	12	13	22	15	0	0	0	0	0	0	0	9.75	0	0	14.2	0.1	1.1
2025	11	12	13	32	15	0	0	0	0	0	0	0	9.78	0	0	14.2	0.1	1.1
2025	11	12	13	42	15	0	0	0	0	0	0	0	9.78	0	0	14.2	0.1	1.1
2025	11	12	13	52	15	0	0	0	0	0	0	0	9.79	0	0	14.2	0.1	1.1
2025	11	12	14	2	15	0	0	0	0	0	0	0	9.79	0	0	14.2	0.1	1.1
2025	11	12	14	12	15	0	0	0	0	0	0	0	9.79	0	0	14.2	0.1	1.1
2025	11	12	14	22	15	0	0	0	0	0	0	0	9.8	0	0	14.2	0.1	1.1
2025	11	12	14	32	15	0	0	0	0	0	0	0	9.8	0	0	14	0.1	1.1
2025	11	12	14	42	15	0	0	0	0	0	0	0	9.81	0	0	14	0.1	1.1
2025	11	12	14	52	15	0	0	0	0	0	0	0	9.8	0	0	14	0.1	1.1
2025	11	12	15	2	15	0	0	0	0	0	0	0	9.79	0	0	14.2	0.1	1.1
2025	11	12	15	12	15	0	0	0	0	0	0	0	9.79	0	0	13.8	0.1	1.1
2025	11	12	15	22	15	0	0	0	0	0	0	0	9.78	0	0	13.6	0.1	1.1
2025	11	12	15	32	15	0	0	0	0	0	0	0	9.78	0	0	13.6	0.1	1.1
2025	11	12	15	42	15	0	0	0	0	0	0	0	9.77	0	0	13.4	0.1	1.1
2025	11	12	15	52	15	0	0	0	0	0	0	0	9.77	0	0	13.2	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	12	16	2	15	0	0	0	0	0	0	0	9.76	0	0	13	0.1	1.1
2025	11	12	16	12	15	0	0	0	0	0	0	0	9.75	0	0	12.8	0.1	1.1
2025	11	12	16	22	15	0	0	0	0	0	0	0	9.75	0	0	12.4	0.1	1.1
2025	11	12	16	32	15	0	0	0	0	0	0	0	9.74	0	0	12	0.1	1.1
2025	11	12	16	42	15	0	0	0	0	0	0	0	9.74	0	0	11.8	0.1	1.1
2025	11	12	16	52	15	0	0	0	0	0	0	0	9.73	0	0	11.4	0.1	1.1
2025	11	12	17	2	15	0	0	0	0	0	0	0	9.74	0	0	11	0.1	1.1
2025	11	12	17	12	15	0	0	0	0	0	0	0	9.73	0	0	10.8	0.1	1.1
2025	11	12	17	22	15	0	0	0	0	0	0	0	9.73	0	0	10.8	0.1	1.1
2025	11	12	17	32	15	0	0	0	0	0	0	0	9.72	0	0	10.8	0.1	1.1
2025	11	12	17	42	15	0	0	0	0	0	0	0	9.71	0	0	10.8	0.1	1.1
2025	11	12	17	52	15	0	0	0	0	0	0	0	9.71	0	0	10.6	0.1	1.1
2025	11	12	18	2	15	0	0	0	0	0	0	0	9.7	0	0	10.6	0.1	1.1
2025	11	12	18	12	15	0	0	0	0	0	0	0	9.69	0	0	10.6	0.1	1.1
2025	11	12	18	22	15	0	0	0	0	0	0	0	9.69	0	0	10.6	0.1	1.1
2025	11	12	18	32	15	0	0	0	0	0	0	0	9.68	0	0	10.8	0.1	1.1
2025	11	12	18	42	15	0	0	0	0	0	0	0	9.67	0	0	10.8	0.1	1.1
2025	11	12	18	52	15	0	0	0	0	0	0	0	9.67	0	0	10.6	0.1	1.1
2025	11	12	19	2	15	0	0	0	0	0	0	0	9.66	0	0	10.6	0.1	1.1
2025	11	12	19	12	15	0	0	0	0	0	0	0	9.65	0	0	10.6	0.1	1.1
2025	11	12	19	22	15	0	0	0	0	0	0	0	9.64	0	0	10.6	0.1	1.1
2025	11	12	19	32	15	0	0	0	0	0	0	0	9.64	0	0	10.6	0.1	1.1
2025	11	12	19	42	15	0	0	0	0	0	0	0	9.63	0	0	10.6	0.1	1.1
2025	11	12	19	52	15	0	0	0	0	0	0	0	9.62	0	0	10.6	0.1	1.1
2025	11	12	20	2	15	0	0	0	0	0	0	0	9.62	0	0	10.6	0.1	1.1
2025	11	12	20	12	15	0	0	0	0	0	0	0	9.62	0	0	10.6	0.1	1.1
2025	11	12	20	22	15	0	0	0	0	0	0	0	9.61	0	0	10.6	0.1	1.1
2025	11	12	20	32	15	0	0	0	0	0	0	0	9.6	0	0	10.8	0.1	1.1
2025	11	12	20	42	15	0	0	0	0	0	0	0	9.59	0	0	10.6	0.1	1.1
2025	11	12	20	52	15	0	0	0	0	0	0	0	9.59	0	0	10.6	0.1	1.1
2025	11	12	21	2	15	0	0	0	0	0	0	0	9.58	0	0	10.6	0.1	1.1
2025	11	12	21	12	15	0	0	0	0	0	0	0	9.57	0	0	10.6	0.1	1.1
2025	11	12	21	22	15	0	0	0	0	0	0	0	9.56	0	0	10.6	0.1	1.1
2025	11	12	21	32	15	0	0	0	0	0	0	0	9.54	0	0	11.2	0.1	1.1
2025	11	12	21	42	15	0	0	0	0	0	0	0	9.53	0	0	11.2	0.1	1.1
2025	11	12	21	52	15	0	0	0	0	0	0	0	9.53	0	0	11.2	0.1	1.1
2025	11	12	22	2	15	0	0	0	0	0	0	0	9.52	0	0	11.2	0.1	1.1
2025	11	12	22	12	15	0	0	0	0	0	0	0	9.51	0	0	11.2	0.1	1.1
2025	11	12	22	22	15	0	0	0	0	0	0	0	9.5	0	0	11.2	0.1	1.1
2025	11	12	22	32	15	0	0	0	0	0	0	0	9.49	0	0	11.2	0.1	1.1
2025	11	12	22	42	15	0	0	0	0	0	0	0	9.48	0	0	11.2	0.1	1.1
2025	11	12	22	52	15	0	0	0	0	0	0	0	9.48	0	0	11.2	0.1	1.1
2025	11	12	23	2	15	0	0	0	0	0	0	0	9.47	0	0	11.2	0.1	1.1
2025	11	12	23	12	15	0	0	0	0	0	0	0	9.46	0	0	11.2	0.1	1.1
2025	11	12	23	22	15	0	0	0	0	0	0	0	9.47	0	0	11.2	0.1	1.1
2025	11	12	23	32	15	0	0	0	0	0	0	0	9.46	0	0	11.2	0.1	1.1
2025	11	12	23	42	15	0	0	0	0	0	0	0	9.45	0	0	11.2	0.1	1.1
2025	11	12	23	52	15	0	0	0	0	0	0	0	9.45	0	0	11.2	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	13	0	2	15	0	0	0	0	0	0	0	9.45	0	0	11.2	0.1	1.1
2025	11	13	0	12	15	0	0	0	0	0	0	0	9.46	0	0	11.2	0.1	1.1
2025	11	13	0	22	15	0	0	0	0	0	0	0	9.45	0	0	11.2	0.1	1.1
2025	11	13	0	32	15	0	0	0	0	0	0	0	9.45	0	0	11.2	0.1	1.1
2025	11	13	0	42	15	0	0	0	0	0	0	0	9.46	0	0	11.2	0.1	1.1
2025	11	13	0	52	15	0	0	0	0	0	0	0	9.46	0	0	11.2	0.1	1.1
2025	11	13	1	2	15	0	0	0	0	0	0	0	9.46	0	0	11.2	0.1	1.1
2025	11	13	1	12	15	0	0	0	0	0	0	0	9.47	0	0	11.2	0.1	1.1
2025	11	13	1	22	15	0	0	0	0	0	0	0	9.47	0	0	11.2	0.1	1.1
2025	11	13	1	32	15	0	0	0	0	0	0	0	9.47	0	0	11.2	0.1	1.1
2025	11	13	1	42	15	0	0	0	0	0	0	0	9.48	0	0	11.2	0.1	1.1
2025	11	13	1	52	15	0	0	0	0	0	0	0	9.49	0	0	11.2	0.1	1.1
2025	11	13	2	2	15	0	0	0	0	0	0	0	9.5	0	0	11.2	0.1	1.1
2025	11	13	2	12	15	0	0	0	0	0	0	0	9.5	0	0	11.2	0.1	1.1
2025	11	13	2	22	15	0	0	0	0	0	0	0	9.51	0	0	11.2	0.1	1.1
2025	11	13	2	32	15	0	0	0	0	0	0	0	9.51	0	0	11.2	0.1	1.1
2025	11	13	2	42	15	0	0	0	0	0	0	0	9.52	0	0	11.2	0.1	1.1
2025	11	13	2	52	15	0	0	0	0	0	0	0	9.53	0	0	11.2	0.1	1.1
2025	11	13	3	2	15	0	0	0	0	0	0	0	9.54	0	0	11.2	0.1	1.1
2025	11	13	3	12	15	0	0	0	0	0	0	0	9.55	0	0	11.2	0.1	1.1
2025	11	13	3	22	15	0	0	0	0	0	0	0	9.56	0	0	11.2	0.1	1.1
2025	11	13	3	32	15	0	0	0	0	0	0	0	9.57	0	0	11.2	0.1	1.1
2025	11	13	3	42	15	0	0	0	0	0	0	0	9.57	0	0	11.2	0.1	1.1
2025	11	13	3	52	15	0	0	0	0	0	0	0	9.59	0	0	11.2	0.1	1.1
2025	11	13	4	2	15	0	0	0	0	0	0	0	9.59	0	0	11.2	0.1	1.1
2025	11	13	4	12	15	0	0	0	0	0	0	0	9.6	0	0	11.2	0.1	1.1
2025	11	13	4	22	15	0	0	0	0	0	0	0	9.6	0	0	11.2	0.1	1.1
2025	11	13	4	32	15	0	0	0	0	0	0	0	9.61	0	0	11.2	0.1	1.1
2025	11	13	4	42	15	0	0	0	0	0	0	0	9.62	0	0	11.2	0.1	1.1
2025	11	13	4	52	15	0	0	0	0	0	0	0	9.62	0	0	11.2	0.1	1.1
2025	11	13	5	2	15	0	0	0	0	0	0	0	9.63	0	0	11.2	0.1	1.1
2025	11	13	5	12	15	0	0	0	0	0	0	0	9.63	0	0	11.2	0.1	1.1
2025	11	13	5	22	15	0	0	0	0	0	0	0	9.64	0	0	11	0.1	1.1
2025	11	13	5	32	15	0	0	0	0	0	0	0	9.64	0	0	11	0.1	1.1
2025	11	13	5	42	15	0	0	0	0	0	0	0	9.64	0	0	11	0.1	1.1
2025	11	13	5	52	15	0	0	0	0	0	0	0	9.65	0	0	11	0.1	1.1
2025	11	13	6	2	15	0	0	0	0	0	0	0	9.65	0	0	11	0.1	1.1
2025	11	13	6	12	15	0	0	0	0	0	0	0	9.65	0	0	11	0.1	1.1
2025	11	13	6	22	15	0	0	0	0	0	0	0	9.65	0	0	11	0.1	1.1
2025	11	13	6	32	15	0	0	0	0	0	0	0	9.66	0	0	11	0.1	1.1
2025	11	13	6	42	15	0	0	0	0	0	0	0	9.66	0	0	11	0.1	1.1
2025	11	13	6	52	15	0	0	0	0	0	0	0	9.66	0	0	11	0.1	1.1
2025	11	13	7	2	15	0	0	0	0	0	0	0	9.67	0	0	11	0.1	1.1
2025	11	13	7	12	15	0	0	0	0	0	0	0	9.67	0	0	11	0.1	1.1
2025	11	13	7	22	15	0	0	0	0	0	0	0	9.67	0	0	11	0.1	1.1
2025	11	13	7	32	15	0	0	0	0	0	0	0	9.68	0	0	11	0.1	1.1
2025	11	13	7	42	15	0	0	0	0	0	0	0	9.68	0	0	11	0.1	1.1
2025	11	13	7	52	15	0	0	0	0	0	0	0	9.68	0	0	11	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	13	8	2	15	0	0	0	0	0	0	0	9.69	0	0	11.2	0.1	1.1
2025	11	13	8	12	15	0	0	0	0	0	0	0	9.69	0	0	11.4	0.1	1.1
2025	11	13	8	22	15	0	0	0	0	0	0	0	9.7	0	0	11.6	0.1	1.1
2025	11	13	8	32	15	0	0	0	0	0	0	0	9.71	0	0	11.8	0.1	1.1
2025	11	13	8	42	15	0	0	0	0	0	0	0	9.72	0	0	12	0.1	1.1
2025	11	13	8	52	15	0	0	0	0	0	0	0	9.74	0	0	12.2	0.1	1.1
2025	11	13	9	2	15	0	0	0	0	0	0	0	9.76	0	0	12.2	0.1	1.1
2025	11	13	9	12	15	0	0	0	0	0	0	0	9.78	0	0	12.2	0.1	1.1
2025	11	13	9	22	15	0	0	0	0	0	0	0	9.81	0	0	12.4	0.1	1.1
2025	11	13	9	32	15	0	0	0	0	0	0	0	9.84	0	0	12.6	0.1	1.1
2025	11	13	9	42	15	0	0	0	0	0	0	0	9.87	0	0	12.6	0.1	1.1
2025	11	13	9	52	15	0	0	0	0	0	0	0	9.89	0	0	13.6	0.1	1.1
2025	11	13	10	2	15	0	0	0	0	0	0	0	9.89	0	0	12.2	0.1	1.1
2025	11	13	10	12	15	0	0	0	0	0	0	0	9.88	0	0	11.8	0.1	1.1
2025	11	13	10	22	15	0	0	0	0	0	0	0	9.88	0	0	11.8	0.1	1.1
2025	11	13	10	32	15	0	0	0	0	0	0	0	9.89	0	0	11.8	0.1	1.1
2025	11	13	10	42	15	0	0	0	0	0	0	0	9.9	0	0	11.8	0.1	1.1
2025	11	13	10	52	15	0	0	0	0	0	0	0	9.9	0	0	11.6	0.1	1.1
2025	11	13	11	2	15	0	0	0	0	0	0	0	9.97	0	0	12.8	0.1	1.1
2025	11	13	11	12	15	0	0	0	0	0	0	0	9.98	0	0	13.4	0.1	1.1
2025	11	13	11	22	15	0	0	0	0	0	0	0	10.02	0	0	12.4	0.1	1.1
2025	11	13	11	32	15	0	0	0	0	0	0	0	10.02	0	0	14.2	0.1	1.1
2025	11	13	11	42	15	0	0	0	0	0	0	0	10.07	0	0	14.2	0.1	1.1
2025	11	13	11	52	15	0	0	0	0	0	0	0	10.11	0	0	14.2	0.1	1.1
2025	11	13	12	2	15	0	0	0	0	0	0	0	10.14	0	0	14.2	0.1	1.1
2025	11	13	12	12	15	0	0	0	0	0	0	0	10.16	0	0	14.2	0.1	1.1
2025	11	13	12	22	15	0	0	0	0	0	0	0	10.19	0	0	14.2	0.1	1.1
2025	11	13	12	32	15	0	0	0	0	0	0	0	10.15	0	0	11.8	0.1	1.1
2025	11	13	12	42	15	0	0	0	0	0	0	0	10.11	0	0	11.4	0.1	1.1
2025	11	13	12	52	15	0	0	0	0	0	0	0	10.09	0	0	11.2	0.1	1.1
2025	11	13	13	2	15	0	0	0	0	0	0	0	10.08	0	0	11.4	0.1	1.1
2025	11	13	13	12	15	0	0	0	0	0	0	0	10.07	0	0	11.2	0.1	1.1
2025	11	13	13	22	15	0	0	0	0	0	0	0	10.07	0	0	11.2	0.1	1.1
2025	11	13	13	32	15	0	0	0	0	0	0	0	10.07	0	0	11.4	0.1	1.1
2025	11	13	13	42	15	0	0	0	0	0	0	0	10.08	0	0	11.2	0.1	1.1
2025	11	13	13	52	15	0	0	0	0	0	0	0	10.08	0	0	11.2	0.1	1.1
2025	11	13	14	2	15	0	0	0	0	0	0	0	10.09	0	0	11.2	0.1	1.1
2025	11	13	14	12	15	0	0	0	0	0	0	0	10.09	0	0	11.2	0.1	1.1
2025	11	13	14	22	15	0	0	0	0	0	0	0	10.12	0	0	12	0.1	1.1
2025	11	13	14	32	15	0	0	0	0	0	0	0	10.12	0	0	11.4	0.1	1.1
2025	11	13	14	42	15	0	0	0	0	0	0	0	10.12	0	0	11.2	0.1	1.1
2025	11	13	14	52	15	0	0	0	0	0	0	0	10.12	0	0	11.2	0.1	1.1
2025	11	13	15	2	15	0	0	0	0	0	0	0	10.14	0	0	11.6	0.1	1.1
2025	11	13	15	12	15	0	0	0	0	0	0	0	10.14	0	0	11.2	0.1	1.1
2025	11	13	15	22	15	0	0	0	0	0	0	0	10.14	0	0	11.2	0.1	1.1
2025	11	13	15	32	15	0	0	0	0	0	0	0	10.14	0	0	11	0.1	1.1
2025	11	13	15	42	15	0	0	0	0	0	0	0	10.16	0	0	12.2	0.1	1.1
2025	11	13	15	52	15	0	0	0	0	0	0	0	10.16	0	0	12.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	13	16	2	15	0	0	0	0	0	0	0	10.15	0	0	10.8	0.1	1.1
2025	11	13	16	12	15	0	0	0	0	0	0	0	10.15	0	0	10.8	0.1	1.1
2025	11	13	16	22	15	0	0	0	0	0	0	0	10.15	0	0	10.8	0.1	1.1
2025	11	13	16	32	15	0	0	0	0	0	0	0	10.16	0	0	11.2	0.1	1.1
2025	11	13	16	42	15	0	0	0	0	0	0	0	10.16	0	0	10.8	0.1	1.1
2025	11	13	16	52	15	0	0	0	0	0	0	0	10.16	0	0	10.8	0.1	1.1
2025	11	13	17	2	15	0	0	0	0	0	0	0	10.16	0	0	10.8	0.1	1.1
2025	11	13	17	12	15	0	0	0	0	0	0	0	10.16	0	0	10.6	0.1	1.1
2025	11	13	17	22	15	0	0	0	0	0	0	0	10.17	0	0	10.6	0.1	1.1
2025	11	13	17	32	15	0	0	0	0	0	0	0	10.17	0	0	10.8	0.1	1.1
2025	11	13	17	42	15	0	0	0	0	0	0	0	10.17	0	0	10.8	0.1	1.1
2025	11	13	17	52	15	0	0	0	0	0	0	0	10.17	0	0	10.8	0.1	1.1
2025	11	13	18	2	15	0	0	0	0	0	0	0	10.18	0	0	10.6	0.1	1.1
2025	11	13	18	12	15	0	0	0	0	0	0	0	10.17	0	0	10.6	0.1	1.1
2025	11	13	18	22	15	0	0	0	0	0	0	0	10.18	0	0	10.6	0.1	1.1
2025	11	13	18	32	15	0	0	0	0	0	0	0	10.18	0	0	10.8	0.1	1.1
2025	11	13	18	42	15	0	0	0	0	0	0	0	10.18	0	0	10.6	0.1	1.1
2025	11	13	18	52	15	0	0	0	0	0	0	0	10.17	0	0	10.6	0.1	1.1
2025	11	13	19	2	15	0	0	0	0	0	0	0	10.17	0	0	10.6	0.1	1.1
2025	11	13	19	12	15	0	0	0	0	0	0	0	10.17	0	0	10.6	0.1	1.1
2025	11	13	19	22	15	0	0	0	0	0	0	0	10.17	0	0	10.6	0.1	1.1
2025	11	13	19	32	15	0	0	0	0	0	0	0	10.16	0	0	10.6	0.1	1.1
2025	11	13	19	42	15	0	0	0	0	0	0	0	10.16	0	0	10.6	0.1	1.1
2025	11	13	19	52	15	0	0	0	0	0	0	0	10.16	0	0	10.6	0.1	1.1
2025	11	13	20	2	15	0	0	0	0	0	0	0	10.15	0	0	10.6	0.1	1.1
2025	11	13	20	12	15	0	0	0	0	0	0	0	10.14	0	0	10.6	0.1	1.1
2025	11	13	20	22	15	0	0	0	0	0	0	0	10.14	0	0	10.6	0.1	1.1
2025	11	13	20	32	15	0	0	0	0	0	0	0	10.14	0	0	10.6	0.1	1.1
2025	11	13	20	42	15	0	0	0	0	0	0	0	10.13	0	0	10.6	0.1	1.1
2025	11	13	20	52	15	0	0	0	0	0	0	0	10.13	0	0	10.6	0.1	1.1
2025	11	13	21	2	15	0	0	0	0	0	0	0	10.12	0	0	10.6	0.1	1.1
2025	11	13	21	12	15	0	0	0	0	0	0	0	10.12	0	0	10.6	0.1	1.1
2025	11	13	21	22	15	0	0	0	0	0	0	0	10.11	0	0	10.6	0.1	1.1
2025	11	13	21	32	15	0	0	0	0	0	0	0	10.12	0	0	11.2	0.1	1.1
2025	11	13	21	42	15	0	0	0	0	0	0	0	10.12	0	0	11.2	0.1	1.1
2025	11	13	21	52	15	0	0	0	0	0	0	0	10.11	0	0	11.2	0.1	1.1
2025	11	13	22	2	15	0	0	0	0	0	0	0	10.12	0	0	11.2	0.1	1.1
2025	11	13	22	12	15	0	0	0	0	0	0	0	10.12	0	0	11.2	0.1	1.1
2025	11	13	22	22	15	0	0	0	0	0	0	0	10.12	0	0	11.2	0.1	1.1
2025	11	13	22	32	15	0	0	0	0	0	0	0	10.13	0	0	11.2	0.1	1.1
2025	11	13	22	42	15	0	0	0	0	0	0	0	10.13	0	0	11.2	0.1	1.1
2025	11	13	22	52	15	0	0	0	0	0	0	0	10.14	0	0	11.2	0.1	1.1
2025	11	13	23	2	15	0	0	0	0	0	0	0	10.15	0	0	11.2	0.1	1.1
2025	11	13	23	12	15	0	0	0	0	0	0	0	10.15	0	0	11.2	0.1	1.1
2025	11	13	23	22	15	0	0	0	0	0	0	0	10.16	0	0	11.2	0.1	1.1
2025	11	13	23	32	15	0	0	0	0	0	0	0	10.17	0	0	11.2	0.1	1.1
2025	11	13	23	42	15	0	0	0	0	0	0	0	10.17	0	0	11.2	0.1	1.1
2025	11	13	23	52	15	0	0	0	0	0	0	0	10.18	0	0	11.2	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	14	0	2	15	0	0	0	0	0	0	0	10.19	0	0	11.2	0.1	1.1
2025	11	14	0	12	15	0	0	0	0	0	0	0	10.19	0	0	11.2	0.1	1.1
2025	11	14	0	22	15	0	0	0	0	0	0	0	10.2	0	0	11.2	0.1	1.1
2025	11	14	0	32	15	0	0	0	0	0	0	0	10.2	0	0	11.2	0.1	1.1
2025	11	14	0	42	15	0	0	0	0	0	0	0	10.21	0	0	11.2	0.1	1.1
2025	11	14	0	52	15	0	0	0	0	0	0	0	10.22	0	0	11.2	0.1	1.1
2025	11	14	1	2	15	0	0	0	0	0	0	0	10.22	0	0	11.2	0.1	1.1
2025	11	14	1	12	15	0	0	0	0	0	0	0	10.22	0	0	11.2	0.1	1.1
2025	11	14	1	22	15	0	0	0	0	0	0	0	10.23	0	0	11.2	0.1	1.1
2025	11	14	1	32	15	0	0	0	0	0	0	0	10.23	0	0	11.2	0.1	1.1
2025	11	14	1	42	15	0	0	0	0	0	0	0	10.23	0	0	11.2	0.1	1.1
2025	11	14	1	52	15	0	0	0	0	0	0	0	10.24	0	0	11.2	0.1	1.1
2025	11	14	2	2	15	0	0	0	0	0	0	0	10.24	0	0	11.2	0.1	1.1
2025	11	14	2	12	15	0	0	0	0	0	0	0	10.25	0	0	11.2	0.1	1.1
2025	11	14	2	22	15	0	0	0	0	0	0	0	10.25	0	0	11.2	0.1	1.1
2025	11	14	2	32	15	0	0	0	0	0	0	0	10.25	0	0	11.2	0.1	1.1
2025	11	14	2	42	15	0	0	0	0	0	0	0	10.26	0	0	11.2	0.1	1.1
2025	11	14	2	52	15	0	0	0	0	0	0	0	10.25	0	0	11.2	0.1	1.1
2025	11	14	3	2	15	0	0	0	0	0	0	0	10.26	0	0	11.2	0.1	1.1
2025	11	14	3	12	15	0	0	0	0	0	0	0	10.26	0	0	11.2	0.1	1.1
2025	11	14	3	22	15	0	0	0	0	0	0	0	10.27	0	0	11.2	0.1	1.1
2025	11	14	3	32	15	0	0	0	0	0	0	0	10.27	0	0	11.2	0.1	1.1
2025	11	14	3	42	15	0	0	0	0	0	0	0	10.28	0	0	11.2	0.1	1.1
2025	11	14	3	52	15	0	0	0	0	0	0	0	10.29	0	0	11.2	0.1	1.1
2025	11	14	4	2	15	0	0	0	0	0	0	0	10.29	0	0	11.2	0.1	1.1
2025	11	14	4	12	15	0	0	0	0	0	0	0	10.29	0	0	11.2	0.1	1.1
2025	11	14	4	22	15	0	0	0	0	0	0	0	10.3	0	0	11.2	0.1	1.1
2025	11	14	4	32	15	0	0	0	0	0	0	0	10.3	0	0	11.2	0.1	1.1
2025	11	14	4	42	15	0	0	0	0	0	0	0	10.31	0	0	11.2	0.1	1.1
2025	11	14	4	52	15	0	0	0	0	0	0	0	10.32	0	0	11.2	0.1	1.1
2025	11	14	5	2	15	0	0	0	0	0	0	0	10.32	0	0	11.2	0.1	1.1
2025	11	14	5	12	15	0	0	0	0	0	0	0	10.33	0	0	11.2	0.1	1.1
2025	11	14	5	22	15	0	0	0	0	0	0	0	10.34	0	0	11.2	0.1	1.1
2025	11	14	5	32	15	0	0	0	0	0	0	0	10.34	0	0	11.2	0.1	1.1
2025	11	14	5	42	15	0	0	0	0	0	0	0	10.35	0	0	11.2	0.1	1.1
2025	11	14	5	52	15	0	0	0	0	0	0	0	10.36	0	0	11.2	0.1	1.1
2025	11	14	6	2	15	0	0	0	0	0	0	0	10.37	0	0	11.2	0.1	1.1
2025	11	14	6	12	15	0	0	0	0	0	0	0	10.38	0	0	11.2	0.1	1.1
2025	11	14	6	22	15	0	0	0	0	0	0	0	10.39	0	0	11.2	0.1	1.1
2025	11	14	6	32	15	0	0	0	0	0	0	0	10.4	0	0	11.2	0.1	1.1
2025	11	14	6	42	15	0	0	0	0	0	0	0	10.42	0	0	11.2	0.1	1.1
2025	11	14	6	52	15	0	0	0	0	0	0	0	10.43	0	0	11.2	0.1	1.1
2025	11	14	7	2	15	0	0	0	0	0	0	0	10.43	0	0	11.2	0.1	1.1
2025	11	14	7	12	15	0	0	0	0	0	0	0	10.45	0	0	11.2	0.1	1.1
2025	11	14	7	22	15	0	0	0	0	0	0	0	10.46	0	0	11.2	0.1	1.1
2025	11	14	7	32	15	0	0	0	0	0	0	0	10.47	0	0	11.2	0.1	1.1
2025	11	14	7	42	15	0	0	0	0	0	0	0	10.48	0	0	11.2	0.1	1.1
2025	11	14	7	52	15	0	0	0	0	0	0	0	10.49	0	0	11.2	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	14	8	2	15	0	0	0	0	0	0	0	10.5	0	0	11.2	0.1	1.1
2025	11	14	8	12	15	0	0	0	0	0	0	0	10.51	0	0	11.2	0.1	1.1
2025	11	14	8	22	15	0	0	0	0	0	0	0	10.52	0	0	11.2	0.1	1.1
2025	11	14	8	32	15	0	0	0	0	0	0	0	10.54	0	0	11.2	0.1	1.1
2025	11	14	8	42	15	0	0	0	0	0	0	0	10.55	0	0	11.2	0.1	1.1
2025	11	14	8	52	15	0	0	0	0	0	0	0	10.56	0	0	11.2	0.1	1.1
2025	11	14	9	2	15	0	0	0	0	0	0	0	10.56	0	0	11.2	0.1	1.1
2025	11	14	9	12	15	0	0	0	0	0	0	0	10.57	0	0	11.2	0.1	1.1
2025	11	14	9	22	15	0	0	0	0	0	0	0	10.58	0	0	11.2	0.1	1.1
2025	11	14	9	32	15	0	0	0	0	0	0	0	10.59	0	0	11.2	0.1	1.1
2025	11	14	9	42	15	0	0	0	0	0	0	0	10.61	0	0	11.2	0.1	1.1
2025	11	14	9	52	15	0	0	0	0	0	0	0	10.61	0	0	11.2	0.1	1.1
2025	11	14	10	2	15	0	0	0	0	0	0	0	10.62	0	0	11.2	0.1	1.1
2025	11	14	10	12	15	0	0	0	0	0	0	0	10.62	0	0	11.2	0.1	1.1
2025	11	14	10	22	15	0	0	0	0	0	0	0	10.64	0	0	11.2	0.1	1.1
2025	11	14	10	32	15	0	0	0	0	0	0	0	10.64	0	0	11.2	0.1	1.1
2025	11	14	10	42	15	0	0	0	0	0	0	0	10.64	0	0	11.2	0.1	1.1
2025	11	14	10	52	15	0	0	0	0	0	0	0	10.64	0	0	11.2	0.1	1.1
2025	11	14	11	2	15	0	0	0	0	0	0	0	10.65	0	0	11.2	0.1	1.1
2025	11	14	11	12	15	0	0	0	0	0	0	0	10.66	0	0	11.4	0.1	1.1
2025	11	14	11	22	15	0	0	0	0	0	0	0	10.69	0	0	11.6	0.1	1.1
2025	11	14	11	32	15	0	0	0	0	0	0	0	10.7	0	0	11.6	0.1	1.1
2025	11	14	11	42	15	0	0	0	0	0	0	0	10.74	0	0	12	0.1	1.1
2025	11	14	11	52	15	0	0	0	0	0	0	0	10.76	0	0	12	0.1	1.1
2025	11	14	12	2	15	0	0	0	0	0	0	0	10.76	0	0	11.8	0.1	1.1
2025	11	14	12	12	15	0	0	0	0	0	0	0	10.77	0	0	11.8	0.1	1.1
2025	11	14	12	22	15	0	0	0	0	0	0	0	10.78	0	0	11.8	0.1	1.1
2025	11	14	12	32	15	0	0	0	0	0	0	0	10.77	0	0	11.6	0.1	1.1
2025	11	14	12	42	15	0	0	0	0	0	0	0	10.77	0	0	11.6	0.1	1.1
2025	11	14	12	52	15	0	0	0	0	0	0	0	10.78	0	0	11.6	0.1	1.1
2025	11	14	13	2	15	0	0	0	0	0	0	0	10.78	0	0	11.6	0.1	1.1
2025	11	14	13	12	15	0	0	0	0	0	0	0	10.79	0	0	11.8	0.1	1.1
2025	11	14	13	22	15	0	0	0	0	0	0	0	10.8	0	0	11.8	0.1	1.1
2025	11	14	13	32	15	0	0	0	0	0	0	0	10.81	0	0	11.8	0.1	1.1
2025	11	14	13	42	15	0	0	0	0	0	0	0	10.81	0	0	11.8	0.1	1.1
2025	11	14	13	52	15	0	0	0	0	0	0	0	10.82	0	0	11.6	0.1	1.1
2025	11	14	14	2	15	0	0	0	0	0	0	0	10.82	0	0	11.6	0.1	1.1
2025	11	14	14	12	15	0	0	0	0	0	0	0	10.83	0	0	11.6	0.1	1.1
2025	11	14	14	22	15	0	0	0	0	0	0	0	10.83	0	0	11.6	0.1	1.1
2025	11	14	14	32	15	0	0	0	0	0	0	0	10.83	0	0	11.6	0.1	1.1
2025	11	14	14	42	15	0	0	0	0	0	0	0	10.83	0	0	11.4	0.1	1.1
2025	11	14	14	52	15	0	0	0	0	0	0	0	10.82	0	0	11.4	0.1	1.1
2025	11	14	15	2	15	0	0	0	0	0	0	0	10.82	0	0	11.4	0.1	1.1
2025	11	14	15	12	15	0	0	0	0	0	0	0	10.82	0	0	11.4	0.1	1.1
2025	11	14	15	22	15	0	0	0	0	0	0	0	10.81	0	0	11.2	0.1	1.1
2025	11	14	15	32	15	0	0	0	0	0	0	0	10.8	0	0	11.2	0.1	1.1
2025	11	14	15	42	15	0	0	0	0	0	0	0	10.8	0	0	11.2	0.1	1.1
2025	11	14	15	52	15	0	0	0	0	0	0	0	10.8	0	0	11.2	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	14	16	2	15	0	0	0	0	0	0	0	10.8	0	0	11.2	0.1	1.1
2025	11	14	16	12	15	0	0	0	0	0	0	0	10.8	0	0	11.2	0.1	1.1
2025	11	14	16	22	15	0	0	0	0	0	0	0	10.8	0	0	11.2	0.1	1.1
2025	11	14	16	32	15	0	0	0	0	0	0	0	10.8	0	0	11.2	0.1	1.1
2025	11	14	16	42	15	0	0	0	0	0	0	0	10.8	0	0	11.2	0.1	1.1
2025	11	14	16	52	15	0	0	0	0	0	0	0	10.79	0	0	11.2	0.1	1.1
2025	11	14	17	2	15	0	0	0	0	0	0	0	10.79	0	0	11.2	0.1	1.1
2025	11	14	17	12	15	0	0	0	0	0	0	0	10.79	0	0	11.2	0.1	1.1
2025	11	14	17	22	15	0	0	0	0	0	0	0	10.79	0	0	11.2	0.1	1.1
2025	11	14	17	32	15	0	0	0	0	0	0	0	10.79	0	0	11.2	0.1	1.1
2025	11	14	17	42	15	0	0	0	0	0	0	0	10.79	0	0	11.2	0.1	1.1
2025	11	14	17	52	15	0	0	0	0	0	0	0	10.79	0	0	11.2	0.1	1.1
2025	11	14	18	2	15	0	0	0	0	0	0	0	10.78	0	0	11.2	0.1	1.1
2025	11	14	18	12	15	0	0	0	0	0	0	0	10.78	0	0	11.2	0.1	1.1
2025	11	14	18	22	15	0	0	0	0	0	0	0	10.78	0	0	11.2	0.1	1.1
2025	11	14	18	32	15	0	0	0	0	0	0	0	10.78	0	0	11.2	0.1	1.1
2025	11	14	18	42	15	0	0	0	0	0	0	0	10.78	0	0	11.2	0.1	1.1
2025	11	14	18	52	15	0	0	0	0	0	0	0	10.78	0	0	11.2	0.1	1.1
2025	11	14	19	2	15	0	0	0	0	0	0	0	10.77	0	0	11.2	0.1	1.1
2025	11	14	19	12	15	0	0	0	0	0	0	0	10.77	0	0	11.2	0.1	1.1
2025	11	14	19	22	15	0	0	0	0	0	0	0	10.77	0	0	11.2	0.1	1.1
2025	11	14	19	32	15	0	0	0	0	0	0	0	10.77	0	0	11.2	0.1	1.1
2025	11	14	19	42	15	0	0	0	0	0	0	0	10.77	0	0	11.2	0.1	1.1
2025	11	14	19	52	15	0	0	0	0	0	0	0	10.77	0	0	11.2	0.1	1.1
2025	11	14	20	2	15	0	0	0	0	0	0	0	10.76	0	0	11.2	0.1	1.1
2025	11	14	20	12	15	0	0	0	0	0	0	0	10.76	0	0	11	0.1	1.1
2025	11	14	20	22	15	0	0	0	0	0	0	0	10.76	0	0	11	0.1	1.1
2025	11	14	20	32	15	0	0	0	0	0	0	0	10.75	0	0	11	0.1	1.1
2025	11	14	20	42	15	0	0	0	0	0	0	0	10.75	0	0	11	0.1	1.1
2025	11	14	20	52	15	0	0	0	0	0	0	0	10.75	0	0	11	0.1	1.1
2025	11	14	21	2	15	0	0	0	0	0	0	0	10.75	0	0	11	0.1	1.1
2025	11	14	21	12	15	0	0	0	0	0	0	0	10.74	0	0	11	0.1	1.1
2025	11	14	21	22	15	0	0	0	0	0	0	0	10.74	0	0	11	0.1	1.1
2025	11	14	21	32	15	0	0	0	0	0	0	0	10.74	0	0	11	0.1	1.1
2025	11	14	21	42	15	0	0	0	0	0	0	0	10.74	0	0	11	0.1	1.1
2025	11	14	21	52	15	0	0	0	0	0	0	0	10.73	0	0	11	0.1	1.1
2025	11	14	22	2	15	0	0	0	0	0	0	0	10.73	0	0	11	0.1	1.1
2025	11	14	22	12	15	0	0	0	0	0	0	0	10.73	0	0	11	0.1	1.1
2025	11	14	22	22	15	0	0	0	0	0	0	0	10.72	0	0	11	0.1	1.1
2025	11	14	22	32	15	0	0	0	0	0	0	0	10.73	0	0	11	0.1	1.1
2025	11	14	22	42	15	0	0	0	0	0	0	0	10.72	0	0	11	0.1	1.1
2025	11	14	22	52	15	0	0	0	0	0	0	0	10.72	0	0	11	0.1	1.1
2025	11	14	23	2	15	0	0	0	0	0	0	0	10.72	0	0	11	0.1	1.1
2025	11	14	23	12	15	0	0	0	0	0	0	0	10.71	0	0	11	0.1	1.1
2025	11	14	23	22	15	0	0	0	0	0	0	0	10.72	0	0	11	0.1	1.1
2025	11	14	23	32	15	0	0	0	0	0	0	0	10.71	0	0	11	0.1	1.1
2025	11	14	23	42	15	0	0	0	0	0	0	0	10.72	0	0	11	0.1	1.1
2025	11	14	23	52	15	0	0	0	0	0	0	0	10.71	0	0	11	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	15	0	2	15	0	0	0	0	0	0	0	10.72	0	0	11	0.1	1.1
2025	11	15	0	12	15	0	0	0	0	0	0	0	10.72	0	0	11	0.1	1.1
2025	11	15	0	22	15	0	0	0	0	0	0	0	10.72	0	0	11	0.1	1.1
2025	11	15	0	32	15	0	0	0	0	0	0	0	10.73	0	0	11	0.1	1.1
2025	11	15	0	42	15	0	0	0	0	0	0	0	10.73	0	0	11	0.1	1.1
2025	11	15	0	52	15	0	0	0	0	0	0	0	10.73	0	0	11	0.1	1.1
2025	11	15	1	2	15	0	0	0	0	0	0	0	10.74	0	0	11	0.1	1.1
2025	11	15	1	12	15	0	0	0	0	0	0	0	10.74	0	0	11	0.1	1.1
2025	11	15	1	22	15	0	0	0	0	0	0	0	10.74	0	0	11	0.1	1.1
2025	11	15	1	32	15	0	0	0	0	0	0	0	10.75	0	0	11	0.1	1.1
2025	11	15	1	42	15	0	0	0	0	0	0	0	10.75	0	0	11	0.1	1.1
2025	11	15	1	52	15	0	0	0	0	0	0	0	10.76	0	0	11	0.1	1.1
2025	11	15	2	2	15	0	0	0	0	0	0	0	10.76	0	0	11	0.1	1.1
2025	11	15	2	12	15	0	0	0	0	0	0	0	10.76	0	0	11	0.1	1.1
2025	11	15	2	22	15	0	0	0	0	0	0	0	10.77	0	0	11	0.1	1.1
2025	11	15	2	32	15	0	0	0	0	0	0	0	10.78	0	0	11	0.1	1.1
2025	11	15	2	42	15	0	0	0	0	0	0	0	10.78	0	0	11	0.1	1.1
2025	11	15	2	52	15	0	0	0	0	0	0	0	10.78	0	0	11	0.1	1.1
2025	11	15	3	2	15	0	0	0	0	0	0	0	10.79	0	0	11	0.1	1.1
2025	11	15	3	12	15	0	0	0	0	0	0	0	10.8	0	0	11	0.1	1.1
2025	11	15	3	22	15	0	0	0	0	0	0	0	10.81	0	0	11	0.1	1.1
2025	11	15	3	32	15	0	0	0	0	0	0	0	10.81	0	0	11	0.1	1.1
2025	11	15	3	42	15	0	0	0	0	0	0	0	10.82	0	0	11	0.1	1.1
2025	11	15	3	52	15	0	0	0	0	0	0	0	10.83	0	0	11	0.1	1.1
2025	11	15	4	2	15	0	0	0	0	0	0	0	10.83	0	0	11	0.1	1.1
2025	11	15	4	12	15	0	0	0	0	0	0	0	10.84	0	0	11	0.1	1.1
2025	11	15	4	22	15	0	0	0	0	0	0	0	10.85	0	0	11	0.1	1.1
2025	11	15	4	32	15	0	0	0	0	0	0	0	10.86	0	0	11	0.1	1.1
2025	11	15	4	42	15	0	0	0	0	0	0	0	10.86	0	0	11	0.1	1.1
2025	11	15	4	52	15	0	0	0	0	0	0	0	10.86	0	0	11	0.1	1.1
2025	11	15	5	2	15	0	0	0	0	0	0	0	10.88	0	0	11	0.1	1.1
2025	11	15	5	12	15	0	0	0	0	0	0	0	10.88	0	0	11	0.1	1.1
2025	11	15	5	22	15	0	0	0	0	0	0	0	10.89	0	0	11	0.1	1.1
2025	11	15	5	32	15	0	0	0	0	0	0	0	10.9	0	0	11	0.1	1.1
2025	11	15	5	42	15	0	0	0	0	0	0	0	10.9	0	0	11	0.1	1.1
2025	11	15	5	52	15	0	0	0	0	0	0	0	10.91	0	0	11	0.1	1.1
2025	11	15	6	2	15	0	0	0	0	0	0	0	10.92	0	0	11	0.1	1.1
2025	11	15	6	12	15	0	0	0	0	0	0	0	10.93	0	0	11	0.1	1.1
2025	11	15	6	22	15	0	0	0	0	0	0	0	10.93	0	0	11	0.1	1.1
2025	11	15	6	32	15	0	0	0	0	0	0	0	10.94	0	0	11	0.1	1.1
2025	11	15	6	42	15	0	0	0	0	0	0	0	10.95	0	0	11	0.1	1.1
2025	11	15	6	52	15	0	0	0	0	0	0	0	10.96	0	0	11	0.1	1.1
2025	11	15	7	2	15	0	0	0	0	0	0	0	10.96	0	0	11	0.1	1.1
2025	11	15	7	12	15	0	0	0	0	0	0	0	10.97	0	0	11	0.1	1.1
2025	11	15	7	22	15	0	0	0	0	0	0	0	10.98	0	0	11	0.1	1.1
2025	11	15	7	32	15	0	0	0	0	0	0	0	10.99	0	0	11	0.1	1.1
2025	11	15	7	42	15	0	0	0	0	0	0	0	11	0	0	11	0.1	1.1
2025	11	15	7	52	15	0	0	0	0	0	0	0	11	0	0	11	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	15	8	2	15	0	0	0	0	0	0	0	11.01	0	0	11	0.1	1.1
2025	11	15	8	12	15	0	0	0	0	0	0	0	11.02	0	0	11	0.1	1.1
2025	11	15	8	22	15	0	0	0	0	0	0	0	11.03	0	0	11	0.1	1.1
2025	11	15	8	32	15	0	0	0	0	0	0	0	11.04	0	0	11	0.1	1.1
2025	11	15	8	42	15	0	0	0	0	0	0	0	11.05	0	0	11	0.1	1.1
2025	11	15	8	52	15	0	0	0	0	0	0	0	11.06	0	0	11	0.1	1.1
2025	11	15	9	2	15	0	0	0	0	0	0	0	11.06	0	0	11	0.1	1.1
2025	11	15	9	12	15	0	0	0	0	0	0	0	11.07	0	0	11	0.1	1.1
2025	11	15	9	22	15	0	0	0	0	0	0	0	11.09	0	0	11	0.1	1.1
2025	11	15	9	32	15	0	0	0	0	0	0	0	11.1	0	0	11	0.1	1.1
2025	11	15	9	42	15	0	0	0	0	0	0	0	11.1	0	0	11	0.1	1.1
2025	11	15	9	52	15	0	0	0	0	0	0	0	11.11	0	0	11	0.1	1.1
2025	11	15	10	2	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1.1
2025	11	15	10	12	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1.1
2025	11	15	10	22	15	0	0	0	0	0	0	0	11.13	0	0	11	0.1	1.1
2025	11	15	10	32	15	0	0	0	0	0	0	0	11.14	0	0	11.2	0.1	1.1
2025	11	15	10	42	15	0	0	0	0	0	0	0	11.14	0	0	11.2	0.1	1.1
2025	11	15	10	52	15	0	0	0	0	0	0	0	11.15	0	0	11.2	0.1	1.1
2025	11	15	11	2	15	0	0	0	0	0	0	0	11.16	0	0	11.2	0.1	1.1
2025	11	15	11	12	15	0	0	0	0	0	0	0	11.17	0	0	11	0.1	1.1
2025	11	15	11	22	15	0	0	0	0	0	0	0	11.17	0	0	11	0.1	1.1
2025	11	15	11	32	15	0	0	0	0	0	0	0	11.18	0	0	11	0.1	1.1
2025	11	15	11	42	15	0	0	0	0	0	0	0	11.18	0	0	11.2	0.1	1.1
2025	11	15	11	52	15	0	0	0	0	0	0	0	11.18	0	0	11	0.1	1.1
2025	11	15	12	2	15	0	0	0	0	0	0	0	11.18	0	0	11.2	0.1	1.1
2025	11	15	12	12	15	0	0	0	0	0	0	0	11.18	0	0	11.2	0.1	1.1
2025	11	15	12	22	15	0	0	0	0	0	0	0	11.19	0	0	11.2	0.1	1.1
2025	11	15	12	32	15	0	0	0	0	0	0	0	11.19	0	0	11.2	0.1	1.1
2025	11	15	12	42	15	0	0	0	0	0	0	0	11.2	0	0	11.2	0.1	1.1
2025	11	15	12	52	15	0	0	0	0	0	0	0	11.2	0	0	11.2	0.1	1.1
2025	11	15	13	2	15	0	0	0	0	0	0	0	11.2	0	0	11	0.1	1.1
2025	11	15	13	12	15	0	0	0	0	0	0	0	11.2	0	0	11	0.1	1.1
2025	11	15	13	22	15	0	0	0	0	0	0	0	11.21	0	0	11	0.1	1.1
2025	11	15	13	32	15	0	0	0	0	0	0	0	11.2	0	0	11	0.1	1.1
2025	11	15	13	42	15	0	0	0	0	0	0	0	11.2	0	0	11	0.1	1.1
2025	11	15	13	52	15	0	0	0	0	0	0	0	11.2	0	0	11	0.1	1.1
2025	11	15	14	2	15	0	0	0	0	0	0	0	11.21	0	0	11	0.1	1.1
2025	11	15	14	12	15	0	0	0	0	0	0	0	11.21	0	0	11	0.1	1.1
2025	11	15	14	22	15	0	0	0	0	0	0	0	11.2	0	0	11	0.1	1.1
2025	11	15	14	32	15	0	0	0	0	0	0	0	11.2	0	0	11	0.1	1.1
2025	11	15	14	42	15	0	0	0	0	0	0	0	11.2	0	0	11	0.1	1.1
2025	11	15	14	52	15	0	0	0	0	0	0	0	11.2	0	0	11	0.1	1.1
2025	11	15	15	2	15	0	0	0	0	0	0	0	11.2	0	0	11	0.1	1.1
2025	11	15	15	12	15	0	0	0	0	0	0	0	11.2	0	0	11	0.1	1.1
2025	11	15	15	22	15	0	0	0	0	0	0	0	11.2	0	0	11	0.1	1.1
2025	11	15	15	32	15	0	0	0	0	0	0	0	11.2	0	0	11	0.1	1.1
2025	11	15	15	42	15	0	0	0	0	0	0	0	11.19	0	0	11	0.1	1.1
2025	11	15	15	52	15	0	0	0	0	0	0	0	11.19	0	0	11	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	15	16	2	15	0	0	0	0	0	0	0	11.19	0	0	11	0.1	1.1
2025	11	15	16	12	15	0	0	0	0	0	0	0	11.19	0	0	11	0.1	1.1
2025	11	15	16	22	15	0	0	0	0	0	0	0	11.19	0	0	11	0.1	1.1
2025	11	15	16	32	15	0	0	0	0	0	0	0	11.18	0	0	11	0.1	1.1
2025	11	15	16	42	15	0	0	0	0	0	0	0	11.18	0	0	11	0.1	1.1
2025	11	15	16	52	15	0	0	0	0	0	0	0	11.19	0	0	11	0.1	1.1
2025	11	15	17	2	15	0	0	0	0	0	0	0	11.18	0	0	11	0.1	1.1
2025	11	15	17	12	15	0	0	0	0	0	0	0	11.18	0	0	11	0.1	1.1
2025	11	15	17	22	15	0	0	0	0	0	0	0	11.18	0	0	11	0.1	1.1
2025	11	15	17	32	15	0	0	0	0	0	0	0	11.17	0	0	11	0.1	1.1
2025	11	15	17	42	15	0	0	0	0	0	0	0	11.17	0	0	11	0.1	1.1
2025	11	15	17	52	15	0	0	0	0	0	0	0	11.17	0	0	11	0.1	1.1
2025	11	15	18	2	15	0	0	0	0	0	0	0	11.17	0	0	11	0.1	1.1
2025	11	15	18	12	15	0	0	0	0	0	0	0	11.16	0	0	11	0.1	1.1
2025	11	15	18	22	15	0	0	0	0	0	0	0	11.16	0	0	11	0.1	1.1
2025	11	15	18	32	15	0	0	0	0	0	0	0	11.16	0	0	11	0.1	1.1
2025	11	15	18	42	15	0	0	0	0	0	0	0	11.16	0	0	11	0.1	1.1
2025	11	15	18	52	15	0	0	0	0	0	0	0	11.15	0	0	11	0.1	1.1
2025	11	15	19	2	15	0	0	0	0	0	0	0	11.15	0	0	11	0.1	1.1
2025	11	15	19	12	15	0	0	0	0	0	0	0	11.15	0	0	11	0.1	1.1
2025	11	15	19	22	15	0	0	0	0	0	0	0	11.14	0	0	11	0.1	1.1
2025	11	15	19	32	15	0	0	0	0	0	0	0	11.14	0	0	11	0.1	1.1
2025	11	15	19	42	15	0	0	0	0	0	0	0	11.14	0	0	11	0.1	1.1
2025	11	15	19	52	15	0	0	0	0	0	0	0	11.13	0	0	11	0.1	1.1
2025	11	15	20	2	15	0	0	0	0	0	0	0	11.13	0	0	11	0.1	1.1
2025	11	15	20	12	15	0	0	0	0	0	0	0	11.13	0	0	11	0.1	1.1
2025	11	15	20	22	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1.1
2025	11	15	20	32	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1.1
2025	11	15	20	42	15	0	0	0	0	0	0	0	11.12	0	0	11	0.1	1.1
2025	11	15	20	52	15	0	0	0	0	0	0	0	11.11	0	0	11	0.1	1.1
2025	11	15	21	2	15	0	0	0	0	0	0	0	11.11	0	0	11	0.1	1.1
2025	11	15	21	12	15	0	0	0	0	0	0	0	11.1	0	0	11	0.1	1.1
2025	11	15	21	22	15	0	0	0	0	0	0	0	11.11	0	0	11	0.1	1.1
2025	11	15	21	32	15	0	0	0	0	0	0	0	11.1	0	0	11	0.1	1.1
2025	11	15	21	42	15	0	0	0	0	0	0	0	11.09	0	0	11	0.1	1.1
2025	11	15	21	52	15	0	0	0	0	0	0	0	11.09	0	0	11	0.1	1.1
2025	11	15	22	2	15	0	0	0	0	0	0	0	11.09	0	0	11	0.1	1.1
2025	11	15	22	12	15	0	0	0	0	0	0	0	11.09	0	0	11	0.1	1.1
2025	11	15	22	22	15	0	0	0	0	0	0	0	11.08	0	0	11	0.1	1.1
2025	11	15	22	32	15	0	0	0	0	0	0	0	11.08	0	0	11	0.1	1.1
2025	11	15	22	42	15	0	0	0	0	0	0	0	11.08	0	0	11	0.1	1.1
2025	11	15	22	52	15	0	0	0	0	0	0	0	11.07	0	0	11	0.1	1.1
2025	11	15	23	2	15	0	0	0	0	0	0	0	11.07	0	0	11	0.1	1.1
2025	11	15	23	12	15	0	0	0	0	0	0	0	11.07	0	0	11	0.1	1.1
2025	11	15	23	22	15	0	0	0	0	0	0	0	11.07	0	0	11	0.1	1.1
2025	11	15	23	32	15	0	0	0	0	0	0	0	11.06	0	0	11	0.1	1.1
2025	11	15	23	42	15	0	0	0	0	0	0	0	11.06	0	0	11	0.1	1.1
2025	11	15	23	52	15	0	0	0	0	0	0	0	11.06	0	0	11	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	16	0	2	15	0	0	0	0	0	0	0	11.05	0	0	11	0.1	1.1
2025	11	16	0	12	15	0	0	0	0	0	0	0	11.04	0	0	11	0.1	1.1
2025	11	16	0	22	15	0	0	0	0	0	0	0	11.03	0	0	11	0.1	1.1
2025	11	16	0	32	15	0	0	0	0	0	0	0	11.03	0	0	11	0.1	1.1
2025	11	16	0	42	15	0	0	0	0	0	0	0	11.03	0	0	11	0.1	1.1
2025	11	16	0	52	15	0	0	0	0	0	0	0	11.02	0	0	11	0.1	1.1
2025	11	16	1	2	15	0	0	0	0	0	0	0	11.02	0	0	11	0.1	1.1
2025	11	16	1	12	15	0	0	0	0	0	0	0	11.01	0	0	11	0.1	1.1
2025	11	16	1	22	15	0	0	0	0	0	0	0	11	0	0	11	0.1	1.1
2025	11	16	1	32	15	0	0	0	0	0	0	0	11	0	0	11	0.1	1.1
2025	11	16	1	42	15	0	0	0	0	0	0	0	11	0	0	11	0.1	1.1
2025	11	16	1	52	15	0	0	0	0	0	0	0	10.99	0	0	11	0.1	1.1
2025	11	16	2	2	15	0	0	0	0	0	0	0	10.99	0	0	11	0.1	1.1
2025	11	16	2	12	15	0	0	0	0	0	0	0	10.98	0	0	11	0.1	1.1
2025	11	16	2	22	15	0	0	0	0	0	0	0	10.97	0	0	11	0.1	1.1
2025	11	16	2	32	15	0	0	0	0	0	0	0	10.97	0	0	11	0.1	1.1
2025	11	16	2	42	15	0	0	0	0	0	0	0	10.97	0	0	11	0.1	1.1
2025	11	16	2	52	15	0	0	0	0	0	0	0	10.97	0	0	11	0.1	1.1
2025	11	16	3	2	15	0	0	0	0	0	0	0	10.96	0	0	11	0.1	1.1
2025	11	16	3	12	15	0	0	0	0	0	0	0	10.96	0	0	11	0.1	1.1
2025	11	16	3	22	15	0	0	0	0	0	0	0	10.95	0	0	11	0.1	1.1
2025	11	16	3	32	15	0	0	0	0	0	0	0	10.95	0	0	11	0.1	1.1
2025	11	16	3	42	15	0	0	0	0	0	0	0	10.95	0	0	11	0.1	1.1
2025	11	16	3	52	15	0	0	0	0	0	0	0	10.94	0	0	11	0.1	1.1
2025	11	16	4	2	15	0	0	0	0	0	0	0	10.94	0	0	11	0.1	1.1
2025	11	16	4	12	15	0	0	0	0	0	0	0	10.93	0	0	11	0.1	1.1
2025	11	16	4	22	15	0	0	0	0	0	0	0	10.93	0	0	11	0.1	1.1
2025	11	16	4	32	15	0	0	0	0	0	0	0	10.93	0	0	11	0.1	1.1
2025	11	16	4	42	15	0	0	0	0	0	0	0	10.93	0	0	11	0.1	1.1
2025	11	16	4	52	15	0	0	0	0	0	0	0	10.92	0	0	11	0.1	1.1
2025	11	16	5	2	15	0	0	0	0	0	0	0	10.91	0	0	11	0.1	1.1
2025	11	16	5	12	15	0	0	0	0	0	0	0	10.91	0	0	11	0.1	1.1
2025	11	16	5	22	15	0	0	0	0	0	0	0	10.9	0	0	11	0.1	1.1
2025	11	16	5	32	15	0	0	0	0	0	0	0	10.9	0	0	11	0.1	1.1
2025	11	16	5	42	15	0	0	0	0	0	0	0	10.89	0	0	11	0.1	1.1
2025	11	16	5	52	15	0	0	0	0	0	0	0	10.89	0	0	11	0.1	1.1
2025	11	16	6	2	15	0	0	0	0	0	0	0	10.88	0	0	11	0.1	1.1
2025	11	16	6	12	15	0	0	0	0	0	0	0	10.88	0	0	11	0.1	1.1
2025	11	16	6	22	15	0	0	0	0	0	0	0	10.87	0	0	11	0.1	1.1
2025	11	16	6	32	15	0	0	0	0	0	0	0	10.87	0	0	11	0.1	1.1
2025	11	16	6	42	15	0	0	0	0	0	0	0	10.87	0	0	11	0.1	1.1
2025	11	16	6	52	15	0	0	0	0	0	0	0	10.86	0	0	11	0.1	1.1
2025	11	16	7	2	15	0	0	0	0	0	0	0	10.86	0	0	11	0.1	1.1
2025	11	16	7	12	15	0	0	0	0	0	0	0	10.86	0	0	11	0.1	1.1
2025	11	16	7	22	15	0	0	0	0	0	0	0	10.85	0	0	11	0.1	1.1
2025	11	16	7	32	15	0	0	0	0	0	0	0	10.85	0	0	11	0.1	1.1
2025	11	16	7	42	15	0	0	0	0	0	0	0	10.84	0	0	11	0.1	1.1
2025	11	16	7	52	15	0	0	0	0	0	0	0	10.84	0	0	11	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	16	8	2	15	0	0	0	0	0	0	0	10.83	0	0	11	0.1	1.1
2025	11	16	8	12	15	0	0	0	0	0	0	0	10.82	0	0	11	0.1	1.1
2025	11	16	8	22	15	0	0	0	0	0	0	0	10.82	0	0	11	0.1	1.1
2025	11	16	8	32	15	0	0	0	0	0	0	0	10.82	0	0	11	0.1	1.1
2025	11	16	8	42	15	0	0	0	0	0	0	0	10.82	0	0	11	0.1	1.1
2025	11	16	8	52	15	0	0	0	0	0	0	0	10.82	0	0	11	0.1	1.1
2025	11	16	9	2	15	0	0	0	0	0	0	0	10.81	0	0	11	0.1	1.1
2025	11	16	9	12	15	0	0	0	0	0	0	0	10.81	0	0	11	0.1	1.1
2025	11	16	9	22	15	0	0	0	0	0	0	0	10.81	0	0	11	0.1	1.1
2025	11	16	9	32	15	0	0	0	0	0	0	0	10.81	0	0	11	0.1	1.1
2025	11	16	9	42	15	0	0	0	0	0	0	0	10.81	0	0	11	0.1	1.1
2025	11	16	9	52	15	0	0	0	0	0	0	0	10.8	0	0	11	0.1	1.1
2025	11	16	10	2	15	0	0	0	0	0	0	0	10.8	0	0	11	0.1	1.1
2025	11	16	10	12	15	0	0	0	0	0	0	0	10.8	0	0	11	0.1	1.1
2025	11	16	10	22	15	0	0	0	0	0	0	0	10.8	0	0	11	0.1	1.1
2025	11	16	10	32	15	0	0	0	0	0	0	0	10.8	0	0	11	0.1	1.1
2025	11	16	10	42	15	0	0	0	0	0	0	0	10.8	0	0	11	0.1	1.1
2025	11	16	10	52	15	0	0	0	0	0	0	0	10.8	0	0	11	0.1	1.1
2025	11	16	11	2	15	0	0	0	0	0	0	0	10.8	0	0	11.2	0.1	1.1
2025	11	16	11	12	15	0	0	0	0	0	0	0	10.81	0	0	11.2	0.1	1.1
2025	11	16	11	22	15	0	0	0	0	0	0	0	10.81	0	0	11.2	0.1	1.1
2025	11	16	11	32	15	0	0	0	0	0	0	0	10.81	0	0	11.2	0.1	1.1
2025	11	16	11	42	15	0	0	0	0	0	0	0	10.82	0	0	11.4	0.1	1.1
2025	11	16	11	52	15	0	0	0	0	0	0	0	10.82	0	0	11.4	0.1	1.1
2025	11	16	12	2	15	0	0	0	0	0	0	0	10.83	0	0	11.6	0.1	1.1
2025	11	16	12	12	15	0	0	0	0	0	0	0	10.84	0	0	11.6	0.1	1.1
2025	11	16	12	22	15	0	0	0	0	0	0	0	10.82	0	0	11.8	0.1	1.1
2025	11	16	12	32	15	0	0	0	0	0	0	0	10.82	0	0	11.6	0.1	1.1
2025	11	16	12	42	15	0	0	0	0	0	0	0	10.81	0	0	11.6	0.1	1.1
2025	11	16	12	52	15	0	0	0	0	0	0	0	10.8	0	0	11.4	0.1	1.1
2025	11	16	13	2	15	0	0	0	0	0	0	0	10.79	0	0	11.4	0.1	1.1
2025	11	16	13	12	15	0	0	0	0	0	0	0	10.8	0	0	11.4	0.1	1.1
2025	11	16	13	22	15	0	0	0	0	0	0	0	10.8	0	0	11.6	0.1	1.1
2025	11	16	13	32	15	0	0	0	0	0	0	0	10.81	0	0	11.8	0.1	1.1
2025	11	16	13	42	15	0	0	0	0	0	0	0	10.82	0	0	11.8	0.1	1.1
2025	11	16	13	52	15	0	0	0	0	0	0	0	10.82	0	0	11.8	0.1	1.1
2025	11	16	14	2	15	0	0	0	0	0	0	0	10.87	0	0	12.4	0.1	1.1
2025	11	16	14	12	15	0	0	0	0	0	0	0	10.91	0	0	12.6	0.1	1.1
2025	11	16	14	22	15	0	0	0	0	0	0	0	10.91	0	0	12.6	0.1	1.1
2025	11	16	14	32	15	0	0	0	0	0	0	0	10.92	0	0	12.6	0.1	1.1
2025	11	16	14	42	15	0	0	0	0	0	0	0	10.88	0	0	12.2	0.1	1.1
2025	11	16	14	52	15	0	0	0	0	0	0	0	10.89	0	0	12.6	0.1	1.1
2025	11	16	15	2	15	0	0	0	0	0	0	0	10.91	0	0	14.2	0.1	1.1
2025	11	16	15	12	15	0	0	0	0	0	0	0	10.9	0	0	12.8	0.1	1.1
2025	11	16	15	22	15	0	0	0	0	0	0	0	10.88	0	0	13.2	0.1	1.1
2025	11	16	15	32	15	0	0	0	0	0	0	0	10.88	0	0	12	0.1	1.1
2025	11	16	15	42	15	0	0	0	0	0	0	0	10.88	0	0	12	0.1	1.1
2025	11	16	15	52	15	0	0	0	0	0	0	0	10.86	0	0	11.8	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	16	16	2	15	0	0	0	0	0	0	0	10.86	0	0	11.8	0.1	1.1
2025	11	16	16	12	15	0	0	0	0	0	0	0	10.85	0	0	11.8	0.1	1.1
2025	11	16	16	22	15	0	0	0	0	0	0	0	10.85	0	0	11.4	0.1	1.1
2025	11	16	16	32	15	0	0	0	0	0	0	0	10.84	0	0	11.4	0.1	1.1
2025	11	16	16	42	15	0	0	0	0	0	0	0	10.84	0	0	11.4	0.1	1.1
2025	11	16	16	52	15	0	0	0	0	0	0	0	10.83	0	0	11.4	0.1	1.1
2025	11	16	17	2	15	0	0	0	0	0	0	0	10.82	0	0	11.4	0.1	1.1
2025	11	16	17	12	15	0	0	0	0	0	0	0	10.82	0	0	11.2	0.1	1.1
2025	11	16	17	22	15	0	0	0	0	0	0	0	10.82	0	0	11.2	0.1	1.1
2025	11	16	17	32	15	0	0	0	0	0	0	0	10.81	0	0	10.8	0.1	1.1
2025	11	16	17	42	15	0	0	0	0	0	0	0	10.81	0	0	10.6	0.1	1.1
2025	11	16	17	52	15	0	0	0	0	0	0	0	10.8	0	0	10.6	0.1	1.1
2025	11	16	18	2	15	0	0	0	0	0	0	0	10.8	0	0	10.6	0.1	1.1
2025	11	16	18	12	15	0	0	0	0	0	0	0	10.79	0	0	10.6	0.1	1.1
2025	11	16	18	22	15	0	0	0	0	0	0	0	10.78	0	0	10.6	0.1	1.1
2025	11	16	18	32	15	0	0	0	0	0	0	0	10.77	0	0	11.4	0.1	1.1
2025	11	16	18	42	15	0	0	0	0	0	0	0	10.75	0	0	11.4	0.1	1.1
2025	11	16	18	52	15	0	0	0	0	0	0	0	10.75	0	0	11.4	0.1	1.1
2025	11	16	19	2	15	0	0	0	0	0	0	0	10.73	0	0	11.4	0.1	1.1
2025	11	16	19	12	15	0	0	0	0	0	0	0	10.72	0	0	11.4	0.1	1.1
2025	11	16	19	22	15	0	0	0	0	0	0	0	10.71	0	0	11.4	0.1	1.1
2025	11	16	19	32	15	0	0	0	0	0	0	0	10.7	0	0	11.4	0.1	1.1
2025	11	16	19	42	15	0	0	0	0	0	0	0	10.69	0	0	11.4	0.1	1.1
2025	11	16	19	52	15	0	0	0	0	0	0	0	10.68	0	0	11.4	0.1	1.1
2025	11	16	20	2	15	0	0	0	0	0	0	0	10.66	0	0	11.4	0.1	1.1
2025	11	16	20	12	15	0	0	0	0	0	0	0	10.65	0	0	11.4	0.1	1.1
2025	11	16	20	22	15	0	0	0	0	0	0	0	10.65	0	0	11.4	0.1	1.1
2025	11	16	20	32	15	0	0	0	0	0	0	0	10.63	0	0	11.4	0.1	1.1
2025	11	16	20	42	15	0	0	0	0	0	0	0	10.62	0	0	11.4	0.1	1.1
2025	11	16	20	52	15	0	0	0	0	0	0	0	10.61	0	0	11.4	0.1	1.1
2025	11	16	21	2	15	0	0	0	0	0	0	0	10.6	0	0	11.4	0.1	1.1
2025	11	16	21	12	15	0	0	0	0	0	0	0	10.59	0	0	11.4	0.1	1.1
2025	11	16	21	22	15	0	0	0	0	0	0	0	10.58	0	0	11.4	0.1	1.1
2025	11	16	21	32	15	0	0	0	0	0	0	0	10.56	0	0	11.4	0.1	1.1
2025	11	16	21	42	15	0	0	0	0	0	0	0	10.55	0	0	11.2	0.1	1.1
2025	11	16	21	52	15	0	0	0	0	0	0	0	10.53	0	0	11.2	0.1	1.1
2025	11	16	22	2	15	0	0	0	0	0	0	0	10.52	0	0	11.2	0.1	1.1
2025	11	16	22	12	15	0	0	0	0	0	0	0	10.5	0	0	11.2	0.1	1.1
2025	11	16	22	22	15	0	0	0	0	0	0	0	10.49	0	0	11.2	0.1	1.1
2025	11	16	22	32	15	0	0	0	0	0	0	0	10.46	0	0	11.2	0.1	1.1
2025	11	16	22	42	15	0	0	0	0	0	0	0	10.45	0	0	11.2	0.1	1.1
2025	11	16	22	52	15	0	0	0	0	0	0	0	10.43	0	0	11.2	0.1	1.1
2025	11	16	23	2	15	0	0	0	0	0	0	0	10.41	0	0	11.2	0.1	1.1
2025	11	16	23	12	15	0	0	0	0	0	0	0	10.39	0	0	11.2	0.1	1.1
2025	11	16	23	22	15	0	0	0	0	0	0	0	10.37	0	0	11.2	0.1	1.1
2025	11	16	23	32	15	0	0	0	0	0	0	0	10.35	0	0	11.2	0.1	1.1
2025	11	16	23	42	15	0	0	0	0	0	0	0	10.34	0	0	11.2	0.1	1.1
2025	11	16	23	52	15	0	0	0	0	0	0	0	10.32	0	0	11.2	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	17	0	2	15	0	0	0	0	0	0	0	10.3	0	0	11.2	0.1	1.1
2025	11	17	0	12	15	0	0	0	0	0	0	0	10.28	0	0	11.2	0.1	1.1
2025	11	17	0	22	15	0	0	0	0	0	0	0	10.26	0	0	11.2	0.1	1.1
2025	11	17	0	32	15	0	0	0	0	0	0	0	10.25	0	0	11.2	0.1	1.1
2025	11	17	0	42	15	0	0	0	0	0	0	0	10.24	0	0	11.2	0.1	1.1
2025	11	17	0	52	15	0	0	0	0	0	0	0	10.22	0	0	11.2	0.1	1.1
2025	11	17	1	2	15	0	0	0	0	0	0	0	10.21	0	0	11.2	0.1	1.1
2025	11	17	1	12	15	0	0	0	0	0	0	0	10.2	0	0	11.2	0.1	1.1
2025	11	17	1	22	15	0	0	0	0	0	0	0	10.19	0	0	11.2	0.1	1.1
2025	11	17	1	32	15	0	0	0	0	0	0	0	10.18	0	0	11.2	0.1	1.1
2025	11	17	1	42	15	0	0	0	0	0	0	0	10.17	0	0	11.2	0.1	1.1
2025	11	17	1	52	15	0	0	0	0	0	0	0	10.16	0	0	11.2	0.1	1.1
2025	11	17	2	2	15	0	0	0	0	0	0	0	10.15	0	0	11.2	0.1	1.1
2025	11	17	2	12	15	0	0	0	0	0	0	0	10.14	0	0	11.2	0.1	1.1
2025	11	17	2	22	15	0	0	0	0	0	0	0	10.13	0	0	11.2	0.1	1.1
2025	11	17	2	32	15	0	0	0	0	0	0	0	10.12	0	0	11.2	0.1	1.1
2025	11	17	2	42	15	0	0	0	0	0	0	0	10.11	0	0	11.2	0.1	1.1
2025	11	17	2	52	15	0	0	0	0	0	0	0	10.1	0	0	11.2	0.1	1.1
2025	11	17	3	2	15	0	0	0	0	0	0	0	10.09	0	0	11.2	0.1	1.1
2025	11	17	3	12	15	0	0	0	0	0	0	0	10.08	0	0	11.2	0.1	1.1
2025	11	17	3	22	15	0	0	0	0	0	0	0	10.07	0	0	11.2	0.1	1.1
2025	11	17	3	32	15	0	0	0	0	0	0	0	10.06	0	0	11.2	0.1	1.1
2025	11	17	3	42	15	0	0	0	0	0	0	0	10.06	0	0	11.2	0.1	1.1
2025	11	17	3	52	15	0	0	0	0	0	0	0	10.04	0	0	11.2	0.1	1.1
2025	11	17	4	2	15	0	0	0	0	0	0	0	10.03	0	0	11.2	0.1	1.1
2025	11	17	4	12	15	0	0	0	0	0	0	0	10.02	0	0	11.2	0.1	1.1
2025	11	17	4	22	15	0	0	0	0	0	0	0	10.01	0	0	11.2	0.1	1.1
2025	11	17	4	32	15	0	0	0	0	0	0	0	10	0	0	11.2	0.1	1.1
2025	11	17	4	42	15	0	0	0	0	0	0	0	9.99	0	0	11.2	0.1	1.1
2025	11	17	4	52	15	0	0	0	0	0	0	0	9.98	0	0	11.2	0.1	1.1
2025	11	17	5	2	15	0	0	0	0	0	0	0	9.97	0	0	11.2	0.1	1.1
2025	11	17	5	12	15	0	0	0	0	0	0	0	9.96	0	0	11.2	0.1	1.1
2025	11	17	5	22	15	0	0	0	0	0	0	0	9.95	0	0	11.2	0.1	1.1
2025	11	17	5	32	15	0	0	0	0	0	0	0	9.94	0	0	11.2	0.1	1.1
2025	11	17	5	42	15	0	0	0	0	0	0	0	9.92	0	0	11.2	0.1	1.1
2025	11	17	5	52	15	0	0	0	0	0	0	0	9.91	0	0	11.2	0.1	1.1
2025	11	17	6	2	15	0	0	0	0	0	0	0	9.9	0	0	11.2	0.1	1.1
2025	11	17	6	12	15	0	0	0	0	0	0	0	9.89	0	0	11.2	0.1	1.1
2025	11	17	6	22	15	0	0	0	0	0	0	0	9.88	0	0	11.2	0.1	1.1
2025	11	17	6	32	15	0	0	0	0	0	0	0	9.86	0	0	11.2	0.1	1.1
2025	11	17	6	42	15	0	0	0	0	0	0	0	9.85	0	0	11.2	0.1	1.1
2025	11	17	6	52	15	0	0	0	0	0	0	0	9.84	0	0	11.2	0.1	1.1
2025	11	17	7	2	15	0	0	0	0	0	0	0	9.83	0	0	11.2	0.1	1.1
2025	11	17	7	12	15	0	0	0	0	0	0	0	9.82	0	0	11.2	0.1	1.1
2025	11	17	7	22	15	0	0	0	0	0	0	0	9.8	0	0	11.2	0.1	1.1
2025	11	17	7	32	15	0	0	0	0	0	0	0	9.79	0	0	11.2	0.1	1.1
2025	11	17	7	42	15	0	0	0	0	0	0	0	9.78	0	0	11.2	0.1	1.1
2025	11	17	7	52	15	0	0	0	0	0	0	0	9.77	0	0	11.2	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	17	8	2	15	0	0	0	0	0	0	0	9.77	0	0	11.2	0.1	1.1
2025	11	17	8	12	15	0	0	0	0	0	0	0	9.76	0	0	11.2	0.1	1.1
2025	11	17	8	22	15	0	0	0	0	0	0	0	9.75	0	0	11.4	0.1	1.1
2025	11	17	8	32	15	0	0	0	0	0	0	0	9.75	0	0	11.4	0.1	1.1
2025	11	17	8	42	15	0	0	0	0	0	0	0	9.75	0	0	11.6	0.1	1.1
2025	11	17	8	52	15	0	0	0	0	0	0	0	9.76	0	0	12	0.1	1.1
2025	11	17	9	2	15	0	0	0	0	0	0	0	9.76	0	0	11.8	0.1	1.1
2025	11	17	9	12	15	0	0	0	0	0	0	0	9.77	0	0	12	0.1	1.1
2025	11	17	9	22	15	0	0	0	0	0	0	0	9.79	0	0	12.4	0.1	1.1
2025	11	17	9	32	15	0	0	0	0	0	0	0	9.8	0	0	12.4	0.1	1.1
2025	11	17	9	42	15	0	0	0	0	0	0	0	9.81	0	0	12.4	0.1	1.1
2025	11	17	9	52	15	0	0	0	0	0	0	0	9.83	0	0	12.4	0.1	1.1
2025	11	17	10	2	15	0	0	0	0	0	0	0	9.85	0	0	12.4	0.1	1.1
2025	11	17	10	12	15	0	0	0	0	0	0	0	9.85	0	0	12.4	0.1	1.1
2025	11	17	10	22	15	0	0	0	0	0	0	0	9.86	0	0	12.4	0.1	1.1
2025	11	17	10	32	15	0	0	0	0	0	0	0	9.87	0	0	12.2	0.1	1.1
2025	11	17	10	42	15	0	0	0	0	0	0	0	9.88	0	0	12.2	0.1	1.1
2025	11	17	10	52	15	0	0	0	0	0	0	0	9.88	0	0	12	0.1	1.1
2025	11	17	11	2	15	0	0	0	0	0	0	0	9.87	0	0	12	0.1	1.1
2025	11	17	11	12	15	0	0	0	0	0	0	0	9.87	0	0	12	0.1	1.1
2025	11	17	11	22	15	0	0	0	0	0	0	0	9.86	0	0	11.8	0.1	1.1
2025	11	17	11	32	15	0	0	0	0	0	0	0	9.85	0	0	11.6	0.1	1.1
2025	11	17	11	42	15	0	0	0	0	0	0	0	9.85	0	0	11.6	0.1	1.1
2025	11	17	11	52	15	0	0	0	0	0	0	0	9.85	0	0	11.8	0.1	1.1
2025	11	17	12	2	15	0	0	0	0	0	0	0	9.86	0	0	11.8	0.1	1.1
2025	11	17	12	12	15	0	0	0	0	0	0	0	9.87	0	0	11.6	0.1	1.1
2025	11	17	12	22	15	0	0	0	0	0	0	0	9.87	0	0	11.6	0.1	1.1
2025	11	17	12	32	15	0	0	0	0	0	0	0	9.87	0	0	11.8	0.1	1.1
2025	11	17	12	42	15	0	0	0	0	0	0	0	9.9	0	0	11.8	0.1	1.1
2025	11	17	12	52	15	0	0	0	0	0	0	0	9.9	0	0	11.8	0.1	1.1
2025	11	17	13	2	15	0	0	0	0	0	0	0	9.92	0	0	12	0.1	1.1
2025	11	17	13	12	15	0	0	0	0	0	0	0	10	0	0	12.4	0.1	1.1
2025	11	17	13	22	15	0	0	0	0	0	0	0	10.01	0	0	12.2	0.1	1.1
2025	11	17	13	32	15	0	0	0	0	0	0	0	10.04	0	0	12.2	0.1	1.1
2025	11	17	13	42	15	0	0	0	0	0	0	0	10	0	0	12	0.1	1.1
2025	11	17	13	52	15	0	0	0	0	0	0	0	9.98	0	0	11.8	0.1	1.1
2025	11	17	14	2	15	0	0	0	0	0	0	0	10	0	0	12	0.1	1.1
2025	11	17	14	12	15	0	0	0	0	0	0	0	10	0	0	12	0.1	1.1
2025	11	17	14	22	15	0	0	0	0	0	0	0	9.99	0	0	11.8	0.1	1.1
2025	11	17	14	32	15	0	0	0	0	0	0	0	9.98	0	0	11.8	0.1	1.1
2025	11	17	14	42	15	0	0	0	0	0	0	0	9.98	0	0	11.8	0.1	1.1
2025	11	17	14	52	15	0	0	0	0	0	0	0	9.98	0	0	11.8	0.1	1.1
2025	11	17	15	2	15	0	0	0	0	0	0	0	9.97	0	0	11.6	0.1	1.1
2025	11	17	15	12	15	0	0	0	0	0	0	0	9.97	0	0	11.6	0.1	1.1
2025	11	17	15	22	15	0	0	0	0	0	0	0	9.97	0	0	11.6	0.1	1.1
2025	11	17	15	32	15	0	0	0	0	0	0	0	9.97	0	0	11.6	0.1	1.1
2025	11	17	15	42	15	0	0	0	0	0	0	0	9.97	0	0	11.6	0.1	1.1
2025	11	17	15	52	15	0	0	0	0	0	0	0	9.96	0	0	11.6	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	17	16	2	15	0	0	0	0	0	0	0	9.96	0	0	11.6	0.1	1.1
2025	11	17	16	12	15	0	0	0	0	0	0	0	9.95	0	0	11.6	0.1	1.1
2025	11	17	16	22	15	0	0	0	0	0	0	0	9.96	0	0	11.6	0.1	1.1
2025	11	17	16	32	15	0	0	0	0	0	0	0	9.95	0	0	11.6	0.1	1.1
2025	11	17	16	42	15	0	0	0	0	0	0	0	9.94	0	0	11.6	0.1	1.1
2025	11	17	16	52	15	0	0	0	0	0	0	0	9.93	0	0	11.6	0.1	1.1
2025	11	17	17	2	15	0	0	0	0	0	0	0	9.92	0	0	11.6	0.1	1.1
2025	11	17	17	12	15	0	0	0	0	0	0	0	9.9	0	0	11.6	0.1	1.1
2025	11	17	17	22	15	0	0	0	0	0	0	0	9.89	0	0	11.4	0.1	1.1
2025	11	17	17	32	15	0	0	0	0	0	0	0	9.87	0	0	11.4	0.1	1.1
2025	11	17	17	42	15	0	0	0	0	0	0	0	9.86	0	0	11.4	0.1	1.1
2025	11	17	17	52	15	0	0	0	0	0	0	0	9.84	0	0	11.4	0.1	1.1
2025	11	17	18	2	15	0	0	0	0	0	0	0	9.83	0	0	11.4	0.1	1.1
2025	11	17	18	12	15	0	0	0	0	0	0	0	9.81	0	0	11.4	0.1	1.1
2025	11	17	18	22	15	0	0	0	0	0	0	0	9.8	0	0	11.4	0.1	1.1
2025	11	17	18	32	15	0	0	0	0	0	0	0	9.78	0	0	11.4	0.1	1.1
2025	11	17	18	42	15	0	0	0	0	0	0	0	9.77	0	0	11.4	0.1	1.1
2025	11	17	18	52	15	0	0	0	0	0	0	0	9.76	0	0	11.4	0.1	1.1
2025	11	17	19	2	15	0	0	0	0	0	0	0	9.75	0	0	11.4	0.1	1.1
2025	11	17	19	12	15	0	0	0	0	0	0	0	9.73	0	0	11.4	0.1	1.1
2025	11	17	19	22	15	0	0	0	0	0	0	0	9.72	0	0	11.4	0.1	1.1
2025	11	17	19	32	15	0	0	0	0	0	0	0	9.7	0	0	11.4	0.1	1.1
2025	11	17	19	42	15	0	0	0	0	0	0	0	9.69	0	0	11.4	0.1	1.1
2025	11	17	19	52	15	0	0	0	0	0	0	0	9.68	0	0	11.4	0.1	1.1
2025	11	17	20	2	15	0	0	0	0	0	0	0	9.67	0	0	11.4	0.1	1.1
2025	11	17	20	12	15	0	0	0	0	0	0	0	9.65	0	0	11.4	0.1	1.1
2025	11	17	20	22	15	0	0	0	0	0	0	0	9.64	0	0	11.4	0.1	1.1
2025	11	17	20	32	15	0	0	0	0	0	0	0	9.63	0	0	11.4	0.1	1.1
2025	11	17	20	42	15	0	0	0	0	0	0	0	9.62	0	0	11.4	0.1	1.1
2025	11	17	20	52	15	0	0	0	0	0	0	0	9.61	0	0	11.4	0.1	1.1
2025	11	17	21	2	15	0	0	0	0	0	0	0	9.6	0	0	11.4	0.1	1.1
2025	11	17	21	12	15	0	0	0	0	0	0	0	9.6	0	0	11.4	0.1	1.1
2025	11	17	21	22	15	0	0	0	0	0	0	0	9.58	0	0	11.4	0.1	1.1
2025	11	17	21	32	15	0	0	0	0	0	0	0	9.57	0	0	11.4	0.1	1.1
2025	11	17	21	42	15	0	0	0	0	0	0	0	9.56	0	0	11.4	0.1	1.1
2025	11	17	21	52	15	0	0	0	0	0	0	0	9.56	0	0	11.2	0.1	1.1
2025	11	17	22	2	15	0	0	0	0	0	0	0	9.55	0	0	11.2	0.1	1.1
2025	11	17	22	12	15	0	0	0	0	0	0	0	9.54	0	0	11.2	0.1	1.1
2025	11	17	22	22	15	0	0	0	0	0	0	0	9.54	0	0	11.2	0.1	1.1
2025	11	17	22	32	15	0	0	0	0	0	0	0	9.53	0	0	11.2	0.1	1.1
2025	11	17	22	42	15	0	0	0	0	0	0	0	9.52	0	0	11.2	0.1	1.1
2025	11	17	22	52	15	0	0	0	0	0	0	0	9.51	0	0	11.2	0.1	1.1
2025	11	17	23	2	15	0	0	0	0	0	0	0	9.5	0	0	11.2	0.1	1.1
2025	11	17	23	12	15	0	0	0	0	0	0	0	9.49	0	0	11.2	0.1	1.1
2025	11	17	23	22	15	0	0	0	0	0	0	0	9.49	0	0	11.2	0.1	1.1
2025	11	17	23	32	15	0	0	0	0	0	0	0	9.48	0	0	11.2	0.1	1.1
2025	11	17	23	42	15	0	0	0	0	0	0	0	9.47	0	0	11.2	0.1	1.1
2025	11	17	23	52	15	0	0	0	0	0	0	0	9.46	0	0	11.2	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	18	0	2	15	0	0	0	0	0	0	0	9.46	0	0	11.2	0.1	1.1
2025	11	18	0	12	15	0	0	0	0	0	0	0	9.46	0	0	11.2	0.1	1.1
2025	11	18	0	22	15	0	0	0	0	0	0	0	9.45	0	0	11.2	0.1	1.1
2025	11	18	0	32	15	0	0	0	0	0	0	0	9.44	0	0	11.2	0.1	1.1
2025	11	18	0	42	15	0	0	0	0	0	0	0	9.44	0	0	11.2	0.1	1.1
2025	11	18	0	52	15	0	0	0	0	0	0	0	9.44	0	0	11.2	0.1	1.1
2025	11	18	1	2	15	0	0	0	0	0	0	0	9.44	0	0	11.2	0.1	1.1
2025	11	18	1	12	15	0	0	0	0	0	0	0	9.43	0	0	11.2	0.1	1.1
2025	11	18	1	22	15	0	0	0	0	0	0	0	9.43	0	0	11.2	0.1	1.1
2025	11	18	1	32	15	0	0	0	0	0	0	0	9.43	0	0	11.2	0.1	1.1
2025	11	18	1	42	15	0	0	0	0	0	0	0	9.42	0	0	11.2	0.1	1.1
2025	11	18	1	52	15	0	0	0	0	0	0	0	9.42	0	0	11.2	0.1	1.1
2025	11	18	2	2	15	0	0	0	0	0	0	0	9.42	0	0	11.2	0.1	1.1
2025	11	18	2	12	15	0	0	0	0	0	0	0	9.41	0	0	11.2	0.1	1.1
2025	11	18	2	22	15	0	0	0	0	0	0	0	9.41	0	0	11.2	0.1	1.1
2025	11	18	2	32	15	0	0	0	0	0	0	0	9.4	0	0	11.2	0.1	1.1
2025	11	18	2	42	15	0	0	0	0	0	0	0	9.4	0	0	11.2	0.1	1.1
2025	11	18	2	52	15	0	0	0	0	0	0	0	9.39	0	0	11.2	0.1	1.1
2025	11	18	3	2	15	0	0	0	0	0	0	0	9.38	0	0	11.2	0.1	1.1
2025	11	18	3	12	15	0	0	0	0	0	0	0	9.38	0	0	11.2	0.1	1.1
2025	11	18	3	22	15	0	0	0	0	0	0	0	9.38	0	0	11.2	0.1	1.1
2025	11	18	3	32	15	0	0	0	0	0	0	0	9.37	0	0	11.2	0.1	1.1
2025	11	18	3	42	15	0	0	0	0	0	0	0	9.37	0	0	11.2	0.1	1.1
2025	11	18	3	52	15	0	0	0	0	0	0	0	9.35	0	0	11.2	0.1	1.1
2025	11	18	4	2	15	0	0	0	0	0	0	0	9.35	0	0	11.2	0.1	1.1
2025	11	18	4	12	15	0	0	0	0	0	0	0	9.34	0	0	11.2	0.1	1.1
2025	11	18	4	22	15	0	0	0	0	0	0	0	9.34	0	0	11.2	0.1	1.1
2025	11	18	4	32	15	0	0	0	0	0	0	0	9.33	0	0	11.2	0.1	1.1
2025	11	18	4	42	15	0	0	0	0	0	0	0	9.32	0	0	11.2	0.1	1.1
2025	11	18	4	52	15	0	0	0	0	0	0	0	9.32	0	0	11.2	0.1	1.1
2025	11	18	5	2	15	0	0	0	0	0	0	0	9.31	0	0	11.2	0.1	1.1
2025	11	18	5	12	15	0	0	0	0	0	0	0	9.3	0	0	11.2	0.1	1.1
2025	11	18	5	22	15	0	0	0	0	0	0	0	9.29	0	0	11.2	0.1	1.1
2025	11	18	5	32	15	0	0	0	0	0	0	0	9.29	0	0	11.2	0.1	1.1
2025	11	18	5	42	15	0	0	0	0	0	0	0	9.27	0	0	11.2	0.1	1.1
2025	11	18	5	52	15	0	0	0	0	0	0	0	9.27	0	0	11.2	0.1	1.1
2025	11	18	6	2	15	0	0	0	0	0	0	0	9.26	0	0	11.2	0.1	1.1
2025	11	18	6	12	15	0	0	0	0	0	0	0	9.26	0	0	11.2	0.1	1.1
2025	11	18	6	22	15	0	0	0	0	0	0	0	9.25	0	0	11.2	0.1	1.1
2025	11	18	6	32	15	0	0	0	0	0	0	0	9.25	0	0	11.2	0.1	1.1
2025	11	18	6	42	15	0	0	0	0	0	0	0	9.24	0	0	11.2	0.1	1.1
2025	11	18	6	52	15	0	0	0	0	0	0	0	9.23	0	0	11.2	0.1	1.1
2025	11	18	7	2	15	0	0	0	0	0	0	0	9.22	0	0	11.2	0.1	1.1
2025	11	18	7	12	15	0	0	0	0	0	0	0	9.22	0	0	11.2	0.1	1.1
2025	11	18	7	22	15	0	0	0	0	0	0	0	9.21	0	0	11.2	0.1	1.1
2025	11	18	7	32	15	0	0	0	0	0	0	0	9.2	0	0	11.2	0.1	1.1
2025	11	18	7	42	15	0	0	0	0	0	0	0	9.2	0	0	11.2	0.1	1.1
2025	11	18	7	52	15	0	0	0	0	0	0	0	9.19	0	0	11.2	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	18	8	2	15	0	0	0	0	0	0	0	9.18	0	0	11.2	0.1	1.1
2025	11	18	8	12	15	0	0	0	0	0	0	0	9.17	0	0	11.2	0.1	1.1
2025	11	18	8	22	15	0	0	0	0	0	0	0	9.17	0	0	11.2	0.1	1.1
2025	11	18	8	32	15	0	0	0	0	0	0	0	9.17	0	0	11.2	0.1	1.1
2025	11	18	8	42	15	0	0	0	0	0	0	0	9.16	0	0	11.2	0.1	1.1
2025	11	18	8	52	15	0	0	0	0	0	0	0	9.16	0	0	11.2	0.1	1.1
2025	11	18	9	2	15	0	0	0	0	0	0	0	9.17	0	0	11.2	0.1	1.1
2025	11	18	9	12	15	0	0	0	0	0	0	0	9.16	0	0	11.2	0.1	1.1
2025	11	18	9	22	15	0	0	0	0	0	0	0	9.16	0	0	11.2	0.1	1.1
2025	11	18	9	32	15	0	0	0	0	0	0	0	9.17	0	0	11.2	0.1	1.1
2025	11	18	9	42	15	0	0	0	0	0	0	0	9.17	0	0	11.2	0.1	1.1
2025	11	18	9	52	15	0	0	0	0	0	0	0	9.16	0	0	11.2	0.1	1.1
2025	11	18	10	2	15	0	0	0	0	0	0	0	9.17	0	0	11.4	0.1	1.1
2025	11	18	10	12	15	0	0	0	0	0	0	0	9.18	0	0	11.4	0.1	1.1
2025	11	18	10	22	15	0	0	0	0	0	0	0	9.18	0	0	11.4	0.1	1.1
2025	11	18	10	32	15	0	0	0	0	0	0	0	9.19	0	0	11.4	0.1	1.1
2025	11	18	10	42	15	0	0	0	0	0	0	0	9.18	0	0	11.4	0.1	1.1
2025	11	18	10	52	15	0	0	0	0	0	0	0	9.18	0	0	11.4	0.1	1.1
2025	11	18	11	2	15	0	0	0	0	0	0	0	9.18	0	0	11.4	0.1	1.1
2025	11	18	11	12	15	0	0	0	0	0	0	0	9.17	0	0	11.2	0.1	1.1
2025	11	18	11	22	15	0	0	0	0	0	0	0	9.17	0	0	11.2	0.1	1.1
2025	11	18	11	32	15	0	0	0	0	0	0	0	9.16	0	0	11.2	0.1	1.1
2025	11	18	11	42	15	0	0	0	0	0	0	0	9.16	0	0	11.2	0.1	1.1
2025	11	18	11	52	15	0	0	0	0	0	0	0	9.15	0	0	11.2	0.1	1.1
2025	11	18	12	2	15	0	0	0	0	0	0	0	9.15	0	0	11.2	0.1	1.1
2025	11	18	12	12	15	0	0	0	0	0	0	0	9.15	0	0	11.4	0.1	1.1
2025	11	18	12	22	15	0	0	0	0	0	0	0	9.16	0	0	11.4	0.1	1.1
2025	11	18	12	32	15	0	0	0	0	0	0	0	9.17	0	0	11.4	0.1	1.1
2025	11	18	12	42	15	0	0	0	0	0	0	0	9.18	0	0	11.4	0.1	1.1
2025	11	18	12	52	15	0	0	0	0	0	0	0	9.17	0	0	11.6	0.1	1.1
2025	11	18	13	2	15	0	0	0	0	0	0	0	9.18	0	0	11.6	0.1	1.1
2025	11	18	13	12	15	0	0	0	0	0	0	0	9.2	0	0	11.6	0.1	1.1
2025	11	18	13	22	15	0	0	0	0	0	0	0	9.19	0	0	11.6	0.1	1.1
2025	11	18	13	32	15	0	0	0	0	0	0	0	9.19	0	0	11.6	0.1	1.1
2025	11	18	13	42	15	0	0	0	0	0	0	0	9.18	0	0	11.4	0.1	1.1
2025	11	18	13	52	15	0	0	0	0	0	0	0	9.16	0	0	11.4	0.1	1.1
2025	11	18	14	2	15	0	0	0	0	0	0	0	9.15	0	0	11.2	0.1	1.1
2025	11	18	14	12	15	0	0	0	0	0	0	0	9.14	0	0	11.2	0.1	1.1
2025	11	18	14	22	15	0	0	0	0	0	0	0	9.13	0	0	11.2	0.1	1.1
2025	11	18	14	32	15	0	0	0	0	0	0	0	9.13	0	0	11.2	0.1	1.1
2025	11	18	14	42	15	0	0	0	0	0	0	0	9.12	0	0	11.2	0.1	1.1
2025	11	18	14	52	15	0	0	0	0	0	0	0	9.11	0	0	11.2	0.1	1.1
2025	11	18	15	2	15	0	0	0	0	0	0	0	9.11	0	0	11.2	0.1	1.1
2025	11	18	15	12	15	0	0	0	0	0	0	0	9.11	0	0	11.2	0.1	1.1
2025	11	18	15	22	15	0	0	0	0	0	0	0	9.1	0	0	11.2	0.1	1.1
2025	11	18	15	32	15	0	0	0	0	0	0	0	9.11	0	0	11.4	0.1	1.1
2025	11	18	15	42	15	0	0	0	0	0	0	0	9.12	0	0	11.4	0.1	1.1
2025	11	18	15	52	15	0	0	0	0	0	0	0	9.12	0	0	11.4	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	18	16	2	15	0	0	0	0	0	0	0	9.11	0	0	11.4	0.1	1.1
2025	11	18	16	12	15	0	0	0	0	0	0	0	9.11	0	0	11.2	0.1	1.1
2025	11	18	16	22	15	0	0	0	0	0	0	0	9.1	0	0	11.2	0.1	1.1
2025	11	18	16	32	15	0	0	0	0	0	0	0	9.09	0	0	11.2	0.1	1.1
2025	11	18	16	42	15	0	0	0	0	0	0	0	9.09	0	0	11.2	0.1	1.1
2025	11	18	16	52	15	0	0	0	0	0	0	0	9.08	0	0	11.2	0.1	1.1
2025	11	18	17	2	15	0	0	0	0	0	0	0	9.07	0	0	11.2	0.1	1.1
2025	11	18	17	12	15	0	0	0	0	0	0	0	9.06	0	0	11.2	0.1	1.1
2025	11	18	17	22	15	0	0	0	0	0	0	0	9.05	0	0	11.2	0.1	1.1
2025	11	18	17	32	15	0	0	0	0	0	0	0	9.04	0	0	11.2	0.1	1.1
2025	11	18	17	42	15	0	0	0	0	0	0	0	9.03	0	0	11.2	0.1	1.1
2025	11	18	17	52	15	0	0	0	0	0	0	0	9.02	0	0	11.2	0.1	1.1
2025	11	18	18	2	15	0	0	0	0	0	0	0	9.01	0	0	11.2	0.1	1.1
2025	11	18	18	12	15	0	0	0	0	0	0	0	9	0	0	11.2	0.1	1.1
2025	11	18	18	22	15	0	0	0	0	0	0	0	9	0	0	11.2	0.1	1.1
2025	11	18	18	32	15	0	0	0	0	0	0	0	8.98	0	0	11.2	0.1	1.1
2025	11	18	18	42	15	0	0	0	0	0	0	0	8.98	0	0	11.2	0.1	1.1
2025	11	18	18	52	15	0	0	0	0	0	0	0	8.97	0	0	11.2	0.1	1.1
2025	11	18	19	2	15	0	0	0	0	0	0	0	8.96	0	0	11.2	0.1	1.1
2025	11	18	19	12	15	0	0	0	0	0	0	0	8.95	0	0	11.2	0.1	1.1
2025	11	18	19	22	15	0	0	0	0	0	0	0	8.94	0	0	11.2	0.1	1.1
2025	11	18	19	32	15	0	0	0	0	0	0	0	8.92	0	0	11.2	0.1	1.1
2025	11	18	19	42	15	0	0	0	0	0	0	0	8.91	0	0	11.2	0.1	1.1
2025	11	18	19	52	15	0	0	0	0	0	0	0	8.9	0	0	11.2	0.1	1.1
2025	11	18	20	2	15	0	0	0	0	0	0	0	8.89	0	0	11.2	0.1	1.1
2025	11	18	20	12	15	0	0	0	0	0	0	0	8.88	0	0	11.2	0.1	1.1
2025	11	18	20	22	15	0	0	0	0	0	0	0	8.86	0	0	11.2	0.1	1.1
2025	11	18	20	32	15	0	0	0	0	0	0	0	8.85	0	0	11.2	0.1	1.1
2025	11	18	20	42	15	0	0	0	0	0	0	0	8.84	0	0	11.2	0.1	1.1
2025	11	18	20	52	15	0	0	0	0	0	0	0	8.83	0	0	11.2	0.1	1.1
2025	11	18	21	2	15	0	0	0	0	0	0	0	8.82	0	0	11.2	0.1	1.1
2025	11	18	21	12	15	0	0	0	0	0	0	0	8.81	0	0	11.2	0.1	1.1
2025	11	18	21	22	15	0	0	0	0	0	0	0	8.8	0	0	11.2	0.1	1.1
2025	11	18	21	32	15	0	0	0	0	0	0	0	8.79	0	0	11.2	0.1	1.1
2025	11	18	21	42	15	0	0	0	0	0	0	0	8.78	0	0	11.2	0.1	1.1
2025	11	18	21	52	15	0	0	0	0	0	0	0	8.77	0	0	11.2	0.1	1.1
2025	11	18	22	2	15	0	0	0	0	0	0	0	8.76	0	0	11.2	0.1	1.1
2025	11	18	22	12	15	0	0	0	0	0	0	0	8.75	0	0	11.2	0.1	1.1
2025	11	18	22	22	15	0	0	0	0	0	0	0	8.74	0	0	11.2	0.1	1.1
2025	11	18	22	32	15	0	0	0	0	0	0	0	8.73	0	0	11.2	0.1	1.1
2025	11	18	22	42	15	0	0	0	0	0	0	0	8.73	0	0	11.2	0.1	1.1
2025	11	18	22	52	15	0	0	0	0	0	0	0	8.72	0	0	11.2	0.1	1.1
2025	11	18	23	2	15	0	0	0	0	0	0	0	8.71	0	0	11.2	0.1	1.1
2025	11	18	23	12	15	0	0	0	0	0	0	0	8.7	0	0	11.2	0.1	1.1
2025	11	18	23	22	15	0	0	0	0	0	0	0	8.69	0	0	11.2	0.1	1.1
2025	11	18	23	32	15	0	0	0	0	0	0	0	8.69	0	0	11.2	0.1	1.1
2025	11	18	23	42	15	0	0	0	0	0	0	0	8.68	0	0	11.2	0.1	1.1
2025	11	18	23	52	15	0	0	0	0	0	0	0	8.68	0	0	11.2	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	19	0	2	15	0	0	0	0	0	0	0	8.67	0	0	11.2	0.1	1.1
2025	11	19	0	12	15	0	0	0	0	0	0	0	8.66	0	0	11.2	0.1	1.1
2025	11	19	0	22	15	0	0	0	0	0	0	0	8.65	0	0	11.2	0.1	1.1
2025	11	19	0	32	15	0	0	0	0	0	0	0	8.65	0	0	11.2	0.1	1.1
2025	11	19	0	42	15	0	0	0	0	0	0	0	8.64	0	0	11.2	0.1	1.1
2025	11	19	0	52	15	0	0	0	0	0	0	0	8.63	0	0	11.2	0.1	1.1
2025	11	19	1	2	15	0	0	0	0	0	0	0	8.63	0	0	11.2	0.1	1.1
2025	11	19	1	12	15	0	0	0	0	0	0	0	8.62	0	0	11.2	0.1	1.1
2025	11	19	1	22	15	0	0	0	0	0	0	0	8.62	0	0	11.2	0.1	1.1
2025	11	19	1	32	15	0	0	0	0	0	0	0	8.61	0	0	11.2	0.1	1.1
2025	11	19	1	42	15	0	0	0	0	0	0	0	8.61	0	0	11.2	0.1	1.1
2025	11	19	1	52	15	0	0	0	0	0	0	0	8.6	0	0	11.2	0.1	1.1
2025	11	19	2	2	15	0	0	0	0	0	0	0	8.6	0	0	11.2	0.1	1.1
2025	11	19	2	12	15	0	0	0	0	0	0	0	8.6	0	0	11.2	0.1	1.1
2025	11	19	2	22	15	0	0	0	0	0	0	0	8.6	0	0	11.2	0.1	1.1
2025	11	19	2	32	15	0	0	0	0	0	0	0	8.6	0	0	11.2	0.1	1.1
2025	11	19	2	42	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	19	2	52	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	19	3	2	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	19	3	12	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	19	3	22	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	19	3	32	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	19	3	42	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	19	3	52	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	19	4	2	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	19	4	12	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	19	4	22	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	4	32	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	4	42	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	19	4	52	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	5	2	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	5	12	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	5	22	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	5	32	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	5	42	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	5	52	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	19	6	2	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	6	12	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	6	22	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	19	6	32	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	6	42	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	6	52	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	7	2	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	7	12	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	7	22	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	7	32	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	7	42	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	7	52	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	19	8	2	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	8	12	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	8	22	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	19	8	32	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	19	8	42	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	19	8	52	15	0	0	0	0	0	0	0	8.6	0	0	11.2	0.1	1.1
2025	11	19	9	2	15	0	0	0	0	0	0	0	8.6	0	0	11.2	0.1	1.1
2025	11	19	9	12	15	0	0	0	0	0	0	0	8.61	0	0	11.6	0.1	1.1
2025	11	19	9	22	15	0	0	0	0	0	0	0	8.62	0	0	11.4	0.1	1.1
2025	11	19	9	32	15	0	0	0	0	0	0	0	8.62	0	0	11.4	0.1	1.1
2025	11	19	9	42	15	0	0	0	0	0	0	0	8.63	0	0	11.4	0.1	1.1
2025	11	19	9	52	15	0	0	0	0	0	0	0	8.64	0	0	12	0.1	1.1
2025	11	19	10	2	15	0	0	0	0	0	0	0	8.67	0	0	12	0.1	1.1
2025	11	19	10	12	15	0	0	0	0	0	0	0	8.7	0	0	12	0.1	1.1
2025	11	19	10	22	15	0	0	0	0	0	0	0	8.7	0	0	11.8	0.1	1.1
2025	11	19	10	32	15	0	0	0	0	0	0	0	8.72	0	0	12	0.1	1.1
2025	11	19	10	42	15	0	0	0	0	0	0	0	8.71	0	0	11.8	0.1	1.1
2025	11	19	10	52	15	0	0	0	0	0	0	0	8.71	0	0	11.8	0.1	1.1
2025	11	19	11	2	15	0	0	0	0	0	0	0	8.73	0	0	12	0.1	1.1
2025	11	19	11	12	15	0	0	0	0	0	0	0	8.74	0	0	12	0.1	1.1
2025	11	19	11	22	15	0	0	0	0	0	0	0	8.75	0	0	12.2	0.1	1.1
2025	11	19	11	32	15	0	0	0	0	0	0	0	8.77	0	0	12	0.1	1.1
2025	11	19	11	42	15	0	0	0	0	0	0	0	8.8	0	0	12.2	0.1	1.1
2025	11	19	11	52	15	0	0	0	0	0	0	0	8.81	0	0	12.2	0.1	1.1
2025	11	19	12	2	15	0	0	0	0	0	0	0	8.85	0	0	14.2	0.1	1.1
2025	11	19	12	12	15	0	0	0	0	0	0	0	8.87	0	0	14.2	0.1	1.1
2025	11	19	12	22	15	0	0	0	0	0	0	0	8.9	0	0	13.8	0.1	1.1
2025	11	19	12	32	15	0	0	0	0	0	0	0	8.91	0	0	13.2	0.1	1.1
2025	11	19	12	42	15	0	0	0	0	0	0	0	8.86	0	0	11.6	0.1	1.1
2025	11	19	12	52	15	0	0	0	0	0	0	0	8.82	0	0	11.8	0.1	1.1
2025	11	19	13	2	15	0	0	0	0	0	0	0	8.87	0	0	12.2	0.1	1.1
2025	11	19	13	12	15	0	0	0	0	0	0	0	8.94	0	0	12.8	0.1	1.1
2025	11	19	13	22	15	0	0	0	0	0	0	0	8.98	0	0	13	0.1	1.1
2025	11	19	13	32	15	0	0	0	0	0	0	0	9	0	0	13.2	0.1	1.1
2025	11	19	13	42	15	0	0	0	0	0	0	0	8.98	0	0	13	0.1	1.1
2025	11	19	13	52	15	0	0	0	0	0	0	0	8.99	0	0	13.4	0.1	1.1
2025	11	19	14	2	15	0	0	0	0	0	0	0	8.99	0	0	13.4	0.1	1.1
2025	11	19	14	12	15	0	0	0	0	0	0	0	8.99	0	0	13	0.1	1.1
2025	11	19	14	22	15	0	0	0	0	0	0	0	8.97	0	0	13.4	0.1	1.1
2025	11	19	14	32	15	0	0	0	0	0	0	0	8.98	0	0	12.2	0.1	1.1
2025	11	19	14	42	15	0	0	0	0	0	0	0	9	0	0	12.4	0.1	1.1
2025	11	19	14	52	15	0	0	0	0	0	0	0	9.01	0	0	12.4	0.1	1.1
2025	11	19	15	2	15	0	0	0	0	0	0	0	9.01	0	0	13.4	0.1	1.1
2025	11	19	15	12	15	0	0	0	0	0	0	0	8.99	0	0	13.4	0.1	1.1
2025	11	19	15	22	15	0	0	0	0	0	0	0	8.99	0	0	13.8	0.1	1.1
2025	11	19	15	32	15	0	0	0	0	0	0	0	8.99	0	0	12	0.1	1.1
2025	11	19	15	42	15	0	0	0	0	0	0	0	8.99	0	0	12	0.1	1.1
2025	11	19	15	52	15	0	0	0	0	0	0	0	8.99	0	0	12	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	19	16	2	15	0	0	0	0	0	0	0	8.98	0	0	12	0.1	1.1
2025	11	19	16	12	15	0	0	0	0	0	0	0	8.98	0	0	11.8	0.1	1.1
2025	11	19	16	22	15	0	0	0	0	0	0	0	8.98	0	0	11.6	0.1	1.1
2025	11	19	16	32	15	0	0	0	0	0	0	0	8.97	0	0	11.6	0.1	1.1
2025	11	19	16	42	15	0	0	0	0	0	0	0	8.97	0	0	11.6	0.1	1.1
2025	11	19	16	52	15	0	0	0	0	0	0	0	8.96	0	0	11.6	0.1	1.1
2025	11	19	17	2	15	0	0	0	0	0	0	0	8.96	0	0	11.6	0.1	1.1
2025	11	19	17	12	15	0	0	0	0	0	0	0	8.95	0	0	11.4	0.1	1.1
2025	11	19	17	22	15	0	0	0	0	0	0	0	8.95	0	0	11.4	0.1	1.1
2025	11	19	17	32	15	0	0	0	0	0	0	0	8.95	0	0	11.4	0.1	1.1
2025	11	19	17	42	15	0	0	0	0	0	0	0	8.95	0	0	11.4	0.1	1.1
2025	11	19	17	52	15	0	0	0	0	0	0	0	8.94	0	0	11.4	0.1	1.1
2025	11	19	18	2	15	0	0	0	0	0	0	0	8.94	0	0	11.4	0.1	1.1
2025	11	19	18	12	15	0	0	0	0	0	0	0	8.94	0	0	11.4	0.1	1.1
2025	11	19	18	22	15	0	0	0	0	0	0	0	8.93	0	0	11.4	0.1	1.1
2025	11	19	18	32	15	0	0	0	0	0	0	0	8.93	0	0	11.4	0.1	1.1
2025	11	19	18	42	15	0	0	0	0	0	0	0	8.92	0	0	11.4	0.1	1.1
2025	11	19	18	52	15	0	0	0	0	0	0	0	8.92	0	0	11.4	0.1	1.1
2025	11	19	19	2	15	0	0	0	0	0	0	0	8.91	0	0	11.4	0.1	1.1
2025	11	19	19	12	15	0	0	0	0	0	0	0	8.91	0	0	11.4	0.1	1.1
2025	11	19	19	22	15	0	0	0	0	0	0	0	8.9	0	0	11.4	0.1	1.1
2025	11	19	19	32	15	0	0	0	0	0	0	0	8.89	0	0	11.4	0.1	1.1
2025	11	19	19	42	15	0	0	0	0	0	0	0	8.88	0	0	11.4	0.1	1.1
2025	11	19	19	52	15	0	0	0	0	0	0	0	8.87	0	0	11.4	0.1	1.1
2025	11	19	20	2	15	0	0	0	0	0	0	0	8.86	0	0	11.4	0.1	1.1
2025	11	19	20	12	15	0	0	0	0	0	0	0	8.85	0	0	11.4	0.1	1.1
2025	11	19	20	22	15	0	0	0	0	0	0	0	8.84	0	0	11.4	0.1	1.1
2025	11	19	20	32	15	0	0	0	0	0	0	0	8.83	0	0	11.4	0.1	1.1
2025	11	19	20	42	15	0	0	0	0	0	0	0	8.82	0	0	11.4	0.1	1.1
2025	11	19	20	52	15	0	0	0	0	0	0	0	8.82	0	0	11.4	0.1	1.1
2025	11	19	21	2	15	0	0	0	0	0	0	0	8.8	0	0	11.4	0.1	1.1
2025	11	19	21	12	15	0	0	0	0	0	0	0	8.8	0	0	11.4	0.1	1.1
2025	11	19	21	22	15	0	0	0	0	0	0	0	8.79	0	0	11.4	0.1	1.1
2025	11	19	21	32	15	0	0	0	0	0	0	0	8.79	0	0	11.4	0.1	1.1
2025	11	19	21	42	15	0	0	0	0	0	0	0	8.78	0	0	11.4	0.1	1.1
2025	11	19	21	52	15	0	0	0	0	0	0	0	8.77	0	0	11.4	0.1	1.1
2025	11	19	22	2	15	0	0	0	0	0	0	0	8.76	0	0	11.4	0.1	1.1
2025	11	19	22	12	15	0	0	0	0	0	0	0	8.76	0	0	11.4	0.1	1.1
2025	11	19	22	22	15	0	0	0	0	0	0	0	8.76	0	0	11.4	0.1	1.1
2025	11	19	22	32	15	0	0	0	0	0	0	0	8.75	0	0	11.4	0.1	1.1
2025	11	19	22	42	15	0	0	0	0	0	0	0	8.74	0	0	11.4	0.1	1.1
2025	11	19	22	52	15	0	0	0	0	0	0	0	8.74	0	0	11.2	0.1	1.1
2025	11	19	23	2	15	0	0	0	0	0	0	0	8.73	0	0	11.2	0.1	1.1
2025	11	19	23	12	15	0	0	0	0	0	0	0	8.73	0	0	11.2	0.1	1.1
2025	11	19	23	22	15	0	0	0	0	0	0	0	8.71	0	0	11.2	0.1	1.1
2025	11	19	23	32	15	0	0	0	0	0	0	0	8.71	0	0	11.2	0.1	1.1
2025	11	19	23	42	15	0	0	0	0	0	0	0	8.7	0	0	11.2	0.1	1.1
2025	11	19	23	52	15	0	0	0	0	0	0	0	8.69	0	0	11.2	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	20	0	2	15	0	0	0	0	0	0	0	8.69	0	0	11.2	0.1	1.1
2025	11	20	0	12	15	0	0	0	0	0	0	0	8.68	0	0	11.2	0.1	1.1
2025	11	20	0	22	15	0	0	0	0	0	0	0	8.67	0	0	11.2	0.1	1.1
2025	11	20	0	32	15	0	0	0	0	0	0	0	8.66	0	0	11.2	0.1	1.1
2025	11	20	0	42	15	0	0	0	0	0	0	0	8.65	0	0	11.2	0.1	1.1
2025	11	20	0	52	15	0	0	0	0	0	0	0	8.64	0	0	11.2	0.1	1.1
2025	11	20	1	2	15	0	0	0	0	0	0	0	8.63	0	0	11.2	0.1	1.1
2025	11	20	1	12	15	0	0	0	0	0	0	0	8.62	0	0	11.2	0.1	1.1
2025	11	20	1	22	15	0	0	0	0	0	0	0	8.62	0	0	11.2	0.1	1.1
2025	11	20	1	32	15	0	0	0	0	0	0	0	8.61	0	0	11.2	0.1	1.1
2025	11	20	1	42	15	0	0	0	0	0	0	0	8.6	0	0	11.2	0.1	1.1
2025	11	20	1	52	15	0	0	0	0	0	0	0	8.6	0	0	11.2	0.1	1.1
2025	11	20	2	2	15	0	0	0	0	0	0	0	8.61	0	0	11.2	0.1	1.1
2025	11	20	2	12	15	0	0	0	0	0	0	0	8.61	0	0	11.2	0.1	1.1
2025	11	20	2	22	15	0	0	0	0	0	0	0	8.6	0	0	11.2	0.1	1.1
2025	11	20	2	32	15	0	0	0	0	0	0	0	8.61	0	0	11.2	0.1	1.1
2025	11	20	2	42	15	0	0	0	0	0	0	0	8.6	0	0	11.2	0.1	1.1
2025	11	20	2	52	15	0	0	0	0	0	0	0	8.61	0	0	11.2	0.1	1.1
2025	11	20	3	2	15	0	0	0	0	0	0	0	8.61	0	0	11.2	0.1	1.1
2025	11	20	3	12	15	0	0	0	0	0	0	0	8.61	0	0	11.2	0.1	1.1
2025	11	20	3	22	15	0	0	0	0	0	0	0	8.61	0	0	11.2	0.1	1.1
2025	11	20	3	32	15	0	0	0	0	0	0	0	8.61	0	0	11.2	0.1	1.1
2025	11	20	3	42	15	0	0	0	0	0	0	0	8.61	0	0	11.2	0.1	1.1
2025	11	20	3	52	15	0	0	0	0	0	0	0	8.61	0	0	11.2	0.1	1.1
2025	11	20	4	2	15	0	0	0	0	0	0	0	8.61	0	0	11.2	0.1	1.1
2025	11	20	4	12	15	0	0	0	0	0	0	0	8.6	0	0	11.2	0.1	1.1
2025	11	20	4	22	15	0	0	0	0	0	0	0	8.6	0	0	11.2	0.1	1.1
2025	11	20	4	32	15	0	0	0	0	0	0	0	8.6	0	0	11.2	0.1	1.1
2025	11	20	4	42	15	0	0	0	0	0	0	0	8.6	0	0	11.2	0.1	1.1
2025	11	20	4	52	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	20	5	2	15	0	0	0	0	0	0	0	8.6	0	0	11.2	0.1	1.1
2025	11	20	5	12	15	0	0	0	0	0	0	0	8.6	0	0	11.2	0.1	1.1
2025	11	20	5	22	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	20	5	32	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	20	5	42	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	20	5	52	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	20	6	2	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	20	6	12	15	0	0	0	0	0	0	0	8.57	0	0	11.2	0.1	1.1
2025	11	20	6	22	15	0	0	0	0	0	0	0	8.57	0	0	11.2	0.1	1.1
2025	11	20	6	32	15	0	0	0	0	0	0	0	8.56	0	0	11.2	0.1	1.1
2025	11	20	6	42	15	0	0	0	0	0	0	0	8.56	0	0	11.2	0.1	1.1
2025	11	20	6	52	15	0	0	0	0	0	0	0	8.56	0	0	11.2	0.1	1.1
2025	11	20	7	2	15	0	0	0	0	0	0	0	8.55	0	0	11	0.1	1.1
2025	11	20	7	12	15	0	0	0	0	0	0	0	8.55	0	0	11	0.1	1.1
2025	11	20	7	22	15	0	0	0	0	0	0	0	8.55	0	0	11	0.1	1.1
2025	11	20	7	32	15	0	0	0	0	0	0	0	8.55	0	0	11	0.1	1.1
2025	11	20	7	42	15	0	0	0	0	0	0	0	8.55	0	0	11	0.1	1.1
2025	11	20	7	52	15	0	0	0	0	0	0	0	8.55	0	0	11	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	20	8	2	15	0	0	0	0	0	0	0	8.56	0	0	11	0.1	1.1
2025	11	20	8	12	15	0	0	0	0	0	0	0	8.56	0	0	11.2	0.1	1.1
2025	11	20	8	22	15	0	0	0	0	0	0	0	8.56	0	0	11.2	0.1	1.1
2025	11	20	8	32	15	0	0	0	0	0	0	0	8.57	0	0	11.2	0.1	1.1
2025	11	20	8	42	15	0	0	0	0	0	0	0	8.58	0	0	11.2	0.1	1.1
2025	11	20	8	52	15	0	0	0	0	0	0	0	8.59	0	0	11.2	0.1	1.1
2025	11	20	9	2	15	0	0	0	0	0	0	0	8.6	0	0	11.2	0.1	1.1
2025	11	20	9	12	15	0	0	0	0	0	0	0	8.61	0	0	11.2	0.1	1.1
2025	11	20	9	22	15	0	0	0	0	0	0	0	8.62	0	0	11.2	0.1	1.1
2025	11	20	9	32	15	0	0	0	0	0	0	0	8.64	0	0	11.2	0.1	1.1
2025	11	20	9	42	15	0	0	0	0	0	0	0	8.65	0	0	11.2	0.1	1.1
2025	11	20	9	52	15	0	0	0	0	0	0	0	8.67	0	0	11.4	0.1	1.1
2025	11	20	10	2	15	0	0	0	0	0	0	0	8.69	0	0	11.2	0.1	1.1
2025	11	20	10	12	15	0	0	0	0	0	0	0	8.7	0	0	11.4	0.1	1.1
2025	11	20	10	22	15	0	0	0	0	0	0	0	8.71	0	0	11.4	0.1	1.1
2025	11	20	10	32	15	0	0	0	0	0	0	0	8.72	0	0	11.4	0.1	1.1
2025	11	20	10	42	15	0	0	0	0	0	0	0	8.73	0	0	11.2	0.1	1.1
2025	11	20	10	52	15	0	0	0	0	0	0	0	8.73	0	0	11.2	0.1	1.1
2025	11	20	11	2	15	0	0	0	0	0	0	0	8.75	0	0	11.2	0.1	1.1
2025	11	20	11	12	15	0	0	0	0	0	0	0	8.75	0	0	11.2	0.1	1.1
2025	11	20	11	22	15	0	0	0	0	0	0	0	8.75	0	0	11.2	0.1	1.1
2025	11	20	11	32	15	0	0	0	0	0	0	0	8.76	0	0	11.2	0.1	1.1
2025	11	20	11	42	15	0	0	0	0	0	0	0	8.76	0	0	11.2	0.1	1.1
2025	11	20	11	52	15	0	0	0	0	0	0	0	8.76	0	0	11.2	0.1	1.1
2025	11	20	12	2	15	0	0	0	0	0	0	0	8.77	0	0	11.2	0.1	1.1
2025	11	20	12	12	15	0	0	0	0	0	0	0	8.78	0	0	11.2	0.1	1.1
2025	11	20	12	22	15	0	0	0	0	0	0	0	8.78	0	0	11.2	0.1	1.1
2025	11	20	12	32	15	0	0	0	0	0	0	0	8.79	0	0	11.2	0.1	1.1
2025	11	20	12	42	15	0	0	0	0	0	0	0	8.78	0	0	11.2	0.1	1.1
2025	11	20	12	52	15	0	0	0	0	0	0	0	8.79	0	0	11.2	0.1	1.1
2025	11	20	13	2	15	0	0	0	0	0	0	0	8.78	0	0	11.2	0.1	1.1
2025	11	20	13	12	15	0	0	0	0	0	0	0	8.78	0	0	11.2	0.1	1.1
2025	11	20	13	22	15	0	0	0	0	0	0	0	8.78	0	0	11.2	0.1	1.1
2025	11	20	13	32	15	0	0	0	0	0	0	0	8.78	0	0	11.2	0.1	1.1
2025	11	20	13	42	15	0	0	0	0	0	0	0	8.77	0	0	11.2	0.1	1.1
2025	11	20	13	52	15	0	0	0	0	0	0	0	8.77	0	0	11.2	0.1	1.1
2025	11	20	14	2	15	0	0	0	0	0	0	0	8.77	0	0	11.2	0.1	1.1
2025	11	20	14	12	15	0	0	0	0	0	0	0	8.77	0	0	11.2	0.1	1.1
2025	11	20	14	22	15	0	0	0	0	0	0	0	8.76	0	0	11.2	0.1	1.1
2025	11	20	14	32	15	0	0	0	0	0	0	0	8.76	0	0	11.2	0.1	1.1
2025	11	20	14	42	15	0	0	0	0	0	0	0	8.75	0	0	11.2	0.1	1.1
2025	11	20	14	52	15	0	0	0	0	0	0	0	8.75	0	0	11.2	0.1	1.1
2025	11	20	15	2	15	0	0	0	0	0	0	0	8.74	0	0	11.2	0.1	1.1
2025	11	20	15	12	15	0	0	0	0	0	0	0	8.73	0	0	11.2	0.1	1.1
2025	11	20	15	22	15	0	0	0	0	0	0	0	8.73	0	0	11.2	0.1	1.1
2025	11	20	15	32	15	0	0	0	0	0	0	0	8.72	0	0	11.2	0.1	1.1
2025	11	20	15	42	15	0	0	0	0	0	0	0	8.72	0	0	11	0.1	1.1
2025	11	20	15	52	15	0	0	0	0	0	0	0	8.71	0	0	11	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	20	16	2	15	0	0	0	0	0	0	0	8.7	0	0	11	0.1	1.1
2025	11	20	16	12	15	0	0	0	0	0	0	0	8.69	0	0	11	0.1	1.1
2025	11	20	16	22	15	0	0	0	0	0	0	0	8.68	0	0	11	0.1	1.1
2025	11	20	16	32	15	0	0	0	0	0	0	0	8.67	0	0	11	0.1	1.1
2025	11	20	16	42	15	0	0	0	0	0	0	0	8.66	0	0	11	0.1	1.1
2025	11	20	16	52	15	0	0	0	0	0	0	0	8.65	0	0	11	0.1	1.1
2025	11	20	17	2	15	0	0	0	0	0	0	0	8.64	0	0	11	0.1	1.1
2025	11	20	17	12	15	0	0	0	0	0	0	0	8.62	0	0	11	0.1	1.1
2025	11	20	17	22	15	0	0	0	0	0	0	0	8.61	0	0	11	0.1	1.1
2025	11	20	17	32	15	0	0	0	0	0	0	0	8.6	0	0	11	0.1	1.1
2025	11	20	17	42	15	0	0	0	0	0	0	0	8.59	0	0	11	0.1	1.1
2025	11	20	17	52	15	0	0	0	0	0	0	0	8.57	0	0	11	0.1	1.1
2025	11	20	18	2	15	0	0	0	0	0	0	0	8.56	0	0	11	0.1	1.1
2025	11	20	18	12	15	0	0	0	0	0	0	0	8.55	0	0	11	0.1	1.1
2025	11	20	18	22	15	0	0	0	0	0	0	0	8.53	0	0	11	0.1	1.1
2025	11	20	18	32	15	0	0	0	0	0	0	0	8.52	0	0	11	0.1	1.1
2025	11	20	18	42	15	0	0	0	0	0	0	0	8.5	0	0	11	0.1	1.1
2025	11	20	18	52	15	0	0	0	0	0	0	0	8.48	0	0	11	0.1	1.1
2025	11	20	19	2	15	0	0	0	0	0	0	0	8.46	0	0	11	0.1	1.1
2025	11	20	19	12	15	0	0	0	0	0	0	0	8.45	0	0	11	0.1	1.1
2025	11	20	19	22	15	0	0	0	0	0	0	0	8.44	0	0	11	0.1	1.1
2025	11	20	19	32	15	0	0	0	0	0	0	0	8.42	0	0	11	0.1	1.1
2025	11	20	19	42	15	0	0	0	0	0	0	0	8.4	0	0	11	0.1	1.1
2025	11	20	19	52	15	0	0	0	0	0	0	0	8.38	0	0	11	0.1	1.1
2025	11	20	20	2	15	0	0	0	0	0	0	0	8.38	0	0	11	0.1	1.1
2025	11	20	20	12	15	0	0	0	0	0	0	0	8.36	0	0	11	0.1	1.1
2025	11	20	20	22	15	0	0	0	0	0	0	0	8.35	0	0	11	0.1	1.1
2025	11	20	20	32	15	0	0	0	0	0	0	0	8.33	0	0	11	0.1	1.1
2025	11	20	20	42	15	0	0	0	0	0	0	0	8.31	0	0	11	0.1	1.1
2025	11	20	20	52	15	0	0	0	0	0	0	0	8.3	0	0	11	0.1	1.1
2025	11	20	21	2	15	0	0	0	0	0	0	0	8.29	0	0	11	0.1	1.1
2025	11	20	21	12	15	0	0	0	0	0	0	0	8.28	0	0	11	0.1	1.1
2025	11	20	21	22	15	0	0	0	0	0	0	0	8.26	0	0	11	0.1	1.1
2025	11	20	21	32	15	0	0	0	0	0	0	0	8.25	0	0	11	0.1	1.1
2025	11	20	21	42	15	0	0	0	0	0	0	0	8.24	0	0	11	0.1	1.1
2025	11	20	21	52	15	0	0	0	0	0	0	0	8.23	0	0	11	0.1	1.1
2025	11	20	22	2	15	0	0	0	0	0	0	0	8.22	0	0	11	0.1	1.1
2025	11	20	22	12	15	0	0	0	0	0	0	0	8.2	0	0	11	0.1	1.1
2025	11	20	22	22	15	0	0	0	0	0	0	0	8.19	0	0	11	0.1	1.1
2025	11	20	22	32	15	0	0	0	0	0	0	0	8.19	0	0	11	0.1	1.1
2025	11	20	22	42	15	0	0	0	0	0	0	0	8.17	0	0	11	0.1	1.1
2025	11	20	22	52	15	0	0	0	0	0	0	0	8.16	0	0	11	0.1	1.1
2025	11	20	23	2	15	0	0	0	0	0	0	0	8.15	0	0	11	0.1	1.1
2025	11	20	23	12	15	0	0	0	0	0	0	0	8.14	0	0	11	0.1	1.1
2025	11	20	23	22	15	0	0	0	0	0	0	0	8.14	0	0	11	0.1	1.1
2025	11	20	23	32	15	0	0	0	0	0	0	0	8.13	0	0	11	0.1	1.1
2025	11	20	23	42	15	0	0	0	0	0	0	0	8.12	0	0	11	0.1	1.1
2025	11	20	23	52	15	0	0	0	0	0	0	0	8.11	0	0	11	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	21	0	2	15	0	0	0	0	0	0	0	8.1	0	0	11	0.1	1.1
2025	11	21	0	12	15	0	0	0	0	0	0	0	8.09	0	0	11	0.1	1.1
2025	11	21	0	22	15	0	0	0	0	0	0	0	8.09	0	0	11	0.1	1.1
2025	11	21	0	32	15	0	0	0	0	0	0	0	8.08	0	0	11	0.1	1.1
2025	11	21	0	42	15	0	0	0	0	0	0	0	8.07	0	0	11	0.1	1.1
2025	11	21	0	52	15	0	0	0	0	0	0	0	8.07	0	0	11	0.1	1.1
2025	11	21	1	2	15	0	0	0	0	0	0	0	8.06	0	0	11	0.1	1.1
2025	11	21	1	12	15	0	0	0	0	0	0	0	8.06	0	0	11	0.1	1.1
2025	11	21	1	22	15	0	0	0	0	0	0	0	8.05	0	0	11	0.1	1.1
2025	11	21	1	32	15	0	0	0	0	0	0	0	8.04	0	0	11	0.1	1.1
2025	11	21	1	42	15	0	0	0	0	0	0	0	8.04	0	0	11	0.1	1.1
2025	11	21	1	52	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1.1
2025	11	21	2	2	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1.1
2025	11	21	2	12	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1.1
2025	11	21	2	22	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1.1
2025	11	21	2	32	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1.1
2025	11	21	2	42	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1.1
2025	11	21	2	52	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1.1
2025	11	21	3	2	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1.1
2025	11	21	3	12	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	3	22	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	3	32	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	3	42	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	3	52	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	4	2	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	4	12	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	4	22	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	4	32	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	4	42	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	4	52	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	5	2	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	5	12	15	0	0	0	0	0	0	0	8	0	0	11	0.1	1.1
2025	11	21	5	22	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	5	32	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	5	42	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	5	52	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	6	2	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	6	12	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	6	22	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	6	32	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	6	42	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1.1
2025	11	21	6	52	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1.1
2025	11	21	7	2	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1.1
2025	11	21	7	12	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1.1
2025	11	21	7	22	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1.1
2025	11	21	7	32	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1.1
2025	11	21	7	42	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1.1
2025	11	21	7	52	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	21	8	2	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1.1
2025	11	21	8	12	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1.1
2025	11	21	8	22	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1.1
2025	11	21	8	32	15	0	0	0	0	0	0	0	8.04	0	0	11	0.1	1.1
2025	11	21	8	42	15	0	0	0	0	0	0	0	8.05	0	0	11	0.1	1.1
2025	11	21	8	52	15	0	0	0	0	0	0	0	8.05	0	0	11	0.1	1.1
2025	11	21	9	2	15	0	0	0	0	0	0	0	8.05	0	0	11	0.1	1.1
2025	11	21	9	12	15	0	0	0	0	0	0	0	8.07	0	0	11	0.1	1.1
2025	11	21	9	22	15	0	0	0	0	0	0	0	8.07	0	0	11	0.1	1.1
2025	11	21	9	32	15	0	0	0	0	0	0	0	8.07	0	0	11	0.1	1.1
2025	11	21	9	42	15	0	0	0	0	0	0	0	8.08	0	0	11	0.1	1.1
2025	11	21	9	52	15	0	0	0	0	0	0	0	8.08	0	0	11	0.1	1.1
2025	11	21	10	2	15	0	0	0	0	0	0	0	8.09	0	0	11	0.1	1.1
2025	11	21	10	12	15	0	0	0	0	0	0	0	8.09	0	0	11	0.1	1.1
2025	11	21	10	22	15	0	0	0	0	0	0	0	8.1	0	0	11	0.1	1.1
2025	11	21	10	32	15	0	0	0	0	0	0	0	8.1	0	0	11.2	0.1	1.1
2025	11	21	10	42	15	0	0	0	0	0	0	0	8.11	0	0	11	0.1	1.1
2025	11	21	10	52	15	0	0	0	0	0	0	0	8.11	0	0	11	0.1	1.1
2025	11	21	11	2	15	0	0	0	0	0	0	0	8.11	0	0	11	0.1	1.1
2025	11	21	11	12	15	0	0	0	0	0	0	0	8.12	0	0	11	0.1	1.1
2025	11	21	11	22	15	0	0	0	0	0	0	0	8.13	0	0	11	0.1	1.1
2025	11	21	11	32	15	0	0	0	0	0	0	0	8.13	0	0	11	0.1	1.1
2025	11	21	11	42	15	0	0	0	0	0	0	0	8.13	0	0	11	0.1	1.1
2025	11	21	11	52	15	0	0	0	0	0	0	0	8.13	0	0	11	0.1	1.1
2025	11	21	12	2	15	0	0	0	0	0	0	0	8.14	0	0	11	0.1	1.1
2025	11	21	12	12	15	0	0	0	0	0	0	0	8.14	0	0	11	0.1	1.1
2025	11	21	12	22	15	0	0	0	0	0	0	0	8.14	0	0	11	0.1	1.1
2025	11	21	12	32	15	0	0	0	0	0	0	0	8.14	0	0	11	0.1	1.1
2025	11	21	12	42	15	0	0	0	0	0	0	0	8.15	0	0	11.2	0.1	1.1
2025	11	21	12	52	15	0	0	0	0	0	0	0	8.16	0	0	11.2	0.1	1.1
2025	11	21	13	2	15	0	0	0	0	0	0	0	8.18	0	0	11.2	0.1	1.1
2025	11	21	13	12	15	0	0	0	0	0	0	0	8.18	0	0	11.2	0.1	1.1
2025	11	21	13	22	15	0	0	0	0	0	0	0	8.18	0	0	11.2	0.1	1.1
2025	11	21	13	32	15	0	0	0	0	0	0	0	8.19	0	0	11.2	0.1	1.1
2025	11	21	13	42	15	0	0	0	0	0	0	0	8.21	0	0	11.2	0.1	1.1
2025	11	21	13	52	15	0	0	0	0	0	0	0	8.22	0	0	11.4	0.1	1.1
2025	11	21	14	2	15	0	0	0	0	0	0	0	8.22	0	0	11.2	0.1	1.1
2025	11	21	14	12	15	0	0	0	0	0	0	0	8.22	0	0	11.2	0.1	1.1
2025	11	21	14	22	15	0	0	0	0	0	0	0	8.22	0	0	11.2	0.1	1.1
2025	11	21	14	32	15	0	0	0	0	0	0	0	8.21	0	0	11.2	0.1	1.1
2025	11	21	14	42	15	0	0	0	0	0	0	0	8.2	0	0	11	0.1	1.1
2025	11	21	14	52	15	0	0	0	0	0	0	0	8.2	0	0	11	0.1	1.1
2025	11	21	15	2	15	0	0	0	0	0	0	0	8.2	0	0	11	0.1	1.1
2025	11	21	15	12	15	0	0	0	0	0	0	0	8.2	0	0	11	0.1	1.1
2025	11	21	15	22	15	0	0	0	0	0	0	0	8.19	0	0	11	0.1	1.1
2025	11	21	15	32	15	0	0	0	0	0	0	0	8.19	0	0	11	0.1	1.1
2025	11	21	15	42	15	0	0	0	0	0	0	0	8.19	0	0	11	0.1	1.1
2025	11	21	15	52	15	0	0	0	0	0	0	0	8.19	0	0	11	0.1	1.1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	21	16	2	15	0	0	0	0	0	0	0	8.19	0	0	11	0.1	1.1
2025	11	21	16	12	15	0	0	0	0	0	0	0	8.18	0	0	11	0.1	1.1
2025	11	21	16	22	15	0	0	0	0	0	0	0	8.18	0	0	11	0.1	1.1
2025	11	21	16	32	15	0	0	0	0	0	0	0	8.17	0	0	11	0.1	1.1
2025	11	21	16	42	15	0	0	0	0	0	0	0	8.18	0	0	11	0.1	1.1
2025	11	21	16	52	15	0	0	0	0	0	0	0	8.17	0	0	11	0.1	1.1
2025	11	21	17	2	15	0	0	0	0	0	0	0	8.17	0	0	11	0.1	1.1
2025	11	21	17	12	15	0	0	0	0	0	0	0	8.16	0	0	11	0.1	1.1
2025	11	21	17	22	15	0	0	0	0	0	0	0	8.16	0	0	11	0.1	1.1
2025	11	21	17	32	15	0	0	0	0	0	0	0	8.16	0	0	11	0.1	1.1
2025	11	21	17	42	15	0	0	0	0	0	0	0	8.15	0	0	11	0.1	1.1
2025	11	21	17	52	15	0	0	0	0	0	0	0	8.14	0	0	11	0.1	1.1
2025	11	21	18	2	15	0	0	0	0	0	0	0	8.14	0	0	11	0.1	1.1
2025	11	21	18	12	15	0	0	0	0	0	0	0	8.13	0	0	11	0.1	1.1
2025	11	21	18	22	15	0	0	0	0	0	0	0	8.12	0	0	11	0.1	1.1
2025	11	21	18	32	15	0	0	0	0	0	0	0	8.13	0	0	11	0.1	1.1
2025	11	21	18	42	15	0	0	0	0	0	0	0	8.12	0	0	11	0.1	1.1
2025	11	21	18	52	15	0	0	0	0	0	0	0	8.12	0	0	11	0.1	1.1
2025	11	21	19	2	15	0	0	0	0	0	0	0	8.11	0	0	11	0.1	1.1
2025	11	21	19	12	15	0	0	0	0	0	0	0	8.11	0	0	11	0.1	1.1
2025	11	21	19	22	15	0	0	0	0	0	0	0	8.11	0	0	11	0.1	1.1
2025	11	21	19	32	15	0	0	0	0	0	0	0	8.1	0	0	11	0.1	1.1
2025	11	21	19	42	15	0	0	0	0	0	0	0	8.1	0	0	11	0.1	1.1
2025	11	21	19	52	15	0	0	0	0	0	0	0	8.1	0	0	11	0.1	1.1
2025	11	21	20	2	15	0	0	0	0	0	0	0	8.09	0	0	11	0.1	1.1
2025	11	21	20	12	15	0	0	0	0	0	0	0	8.09	0	0	11	0.1	1
2025	11	21	20	22	15	0	0	0	0	0	0	0	8.08	0	0	11	0.1	1
2025	11	21	20	32	15	0	0	0	0	0	0	0	8.07	0	0	11	0.1	1
2025	11	21	20	42	15	0	0	0	0	0	0	0	8.06	0	0	11	0.1	1
2025	11	21	20	52	15	0	0	0	0	0	0	0	8.07	0	0	11	0.1	1
2025	11	21	21	2	15	0	0	0	0	0	0	0	8.06	0	0	11	0.1	1
2025	11	21	21	12	15	0	0	0	0	0	0	0	8.05	0	0	11	0.1	1
2025	11	21	21	22	15	0	0	0	0	0	0	0	8.05	0	0	11	0.1	1
2025	11	21	21	32	15	0	0	0	0	0	0	0	8.04	0	0	11	0.1	1
2025	11	21	21	42	15	0	0	0	0	0	0	0	8.04	0	0	11	0.1	1
2025	11	21	21	52	15	0	0	0	0	0	0	0	8.04	0	0	11	0.1	1
2025	11	21	22	2	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1
2025	11	21	22	12	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1
2025	11	21	22	22	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1
2025	11	21	22	32	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1
2025	11	21	22	42	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1
2025	11	21	22	52	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1
2025	11	21	23	2	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1
2025	11	21	23	12	15	0	0	0	0	0	0	0	8	0	0	11	0.1	1
2025	11	21	23	22	15	0	0	0	0	0	0	0	8	0	0	11	0.1	1
2025	11	21	23	32	15	0	0	0	0	0	0	0	8	0	0	11	0.1	1
2025	11	21	23	42	15	0	0	0	0	0	0	0	7.99	0	0	11	0.1	1
2025	11	21	23	52	15	0	0	0	0	0	0	0	7.99	0	0	11	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	22	0	2	15	0	0	0	0	0	0	0	7.99	0	0	11	0.1	1
2025	11	22	0	12	15	0	0	0	0	0	0	0	7.99	0	0	11	0.1	1
2025	11	22	0	22	15	0	0	0	0	0	0	0	7.99	0	0	11	0.1	1
2025	11	22	0	32	15	0	0	0	0	0	0	0	7.99	0	0	11	0.1	1
2025	11	22	0	42	15	0	0	0	0	0	0	0	7.99	0	0	11	0.1	1
2025	11	22	0	52	15	0	0	0	0	0	0	0	7.98	0	0	11	0.1	1
2025	11	22	1	2	15	0	0	0	0	0	0	0	7.99	0	0	11	0.1	1
2025	11	22	1	12	15	0	0	0	0	0	0	0	7.99	0	0	11	0.1	1
2025	11	22	1	22	15	0	0	0	0	0	0	0	7.99	0	0	11	0.1	1
2025	11	22	1	32	15	0	0	0	0	0	0	0	7.99	0	0	11	0.1	1
2025	11	22	1	42	15	0	0	0	0	0	0	0	7.99	0	0	11	0.1	1
2025	11	22	1	52	15	0	0	0	0	0	0	0	7.99	0	0	11	0.1	1
2025	11	22	2	2	15	0	0	0	0	0	0	0	7.99	0	0	11	0.1	1
2025	11	22	2	12	15	0	0	0	0	0	0	0	7.99	0	0	11	0.1	1
2025	11	22	2	22	15	0	0	0	0	0	0	0	8	0	0	11	0.1	1
2025	11	22	2	32	15	0	0	0	0	0	0	0	8	0	0	11	0.1	1
2025	11	22	2	42	15	0	0	0	0	0	0	0	7.99	0	0	11	0.1	1
2025	11	22	2	52	15	0	0	0	0	0	0	0	8	0	0	11	0.1	1
2025	11	22	3	2	15	0	0	0	0	0	0	0	8	0	0	11	0.1	1
2025	11	22	3	12	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1
2025	11	22	3	22	15	0	0	0	0	0	0	0	8	0	0	11	0.1	1
2025	11	22	3	32	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1
2025	11	22	3	42	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1
2025	11	22	3	52	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1
2025	11	22	4	2	15	0	0	0	0	0	0	0	8.01	0	0	11	0.1	1
2025	11	22	4	12	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1
2025	11	22	4	22	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1
2025	11	22	4	32	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1
2025	11	22	4	42	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1
2025	11	22	4	52	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1
2025	11	22	5	2	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1
2025	11	22	5	12	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1
2025	11	22	5	22	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1
2025	11	22	5	32	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1
2025	11	22	5	42	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1
2025	11	22	5	52	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1
2025	11	22	6	2	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1
2025	11	22	6	12	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1
2025	11	22	6	22	15	0	0	0	0	0	0	0	8.02	0	0	11	0.1	1
2025	11	22	6	32	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1
2025	11	22	6	42	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1
2025	11	22	6	52	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1
2025	11	22	7	2	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1
2025	11	22	7	12	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1
2025	11	22	7	22	15	0	0	0	0	0	0	0	8.04	0	0	11	0.1	1
2025	11	22	7	32	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1
2025	11	22	7	42	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1
2025	11	22	7	52	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	22	8	2	15	0	0	0	0	0	0	0	8.03	0	0	11	0.1	1
2025	11	22	8	12	15	0	0	0	0	0	0	0	8.04	0	0	11	0.1	1
2025	11	22	8	22	15	0	0	0	0	0	0	0	8.04	0	0	11	0.1	1
2025	11	22	8	32	15	0	0	0	0	0	0	0	8.04	0	0	11	0.1	1
2025	11	22	8	42	15	0	0	0	0	0	0	0	8.04	0	0	11	0.1	1
2025	11	22	8	52	15	0	0	0	0	0	0	0	8.04	0	0	11	0.1	1
2025	11	22	9	2	15	0	0	0	0	0	0	0	8.04	0	0	11	0.1	1
2025	11	22	9	12	15	0	0	0	0	0	0	0	8.05	0	0	11	0.1	1
2025	11	22	9	22	15	0	0	0	0	0	0	0	8.06	0	0	11	0.1	1
2025	11	22	9	32	15	0	0	0	0	0	0	0	8.06	0	0	11	0.1	1
2025	11	22	9	42	15	0	0	0	0	0	0	0	8.07	0	0	11	0.1	1
2025	11	22	9	52	15	0	0	0	0	0	0	0	8.07	0	0	11	0.1	1
2025	11	22	10	2	15	0	0	0	0	0	0	0	8.08	0	0	11	0.1	1
2025	11	22	10	12	15	0	0	0	0	0	0	0	8.08	0	0	11	0.1	1
2025	11	22	10	22	15	0	0	0	0	0	0	0	8.1	0	0	11	0.1	1
2025	11	22	10	32	15	0	0	0	0	0	0	0	8.1	0	0	11	0.1	1
2025	11	22	10	42	15	0	0	0	0	0	0	0	8.1	0	0	11	0.1	1
2025	11	22	10	52	15	0	0	0	0	0	0	0	8.11	0	0	11	0.1	1
2025	11	22	11	2	15	0	0	0	0	0	0	0	8.11	0	0	11	0.1	1
2025	11	22	11	12	15	0	0	0	0	0	0	0	8.12	0	0	11.2	0.1	1
2025	11	22	11	22	15	0	0	0	0	0	0	0	8.12	0	0	11.2	0.1	1
2025	11	22	11	32	15	0	0	0	0	0	0	0	8.13	0	0	11.2	0.1	1
2025	11	22	11	42	15	0	0	0	0	0	0	0	8.14	0	0	11.2	0.1	1
2025	11	22	11	52	15	0	0	0	0	0	0	0	8.14	0	0	11.2	0.1	1
2025	11	22	12	2	15	0	0	0	0	0	0	0	8.15	0	0	11.2	0.1	1
2025	11	22	12	12	15	0	0	0	0	0	0	0	8.15	0	0	11.2	0.1	1
2025	11	22	12	22	15	0	0	0	0	0	0	0	8.16	0	0	11.2	0.1	1
2025	11	22	12	32	15	0	0	0	0	0	0	0	8.16	0	0	11.2	0.1	1
2025	11	22	12	42	15	0	0	0	0	0	0	0	8.16	0	0	11.2	0.1	1
2025	11	22	12	52	15	0	0	0	0	0	0	0	8.19	0	0	11.6	0.1	1
2025	11	22	13	2	15	0	0	0	0	0	0	0	8.22	0	0	11.6	0.1	1
2025	11	22	13	12	15	0	0	0	0	0	0	0	8.24	0	0	11.4	0.1	1
2025	11	22	13	22	15	0	0	0	0	0	0	0	8.24	0	0	11.4	0.1	1
2025	11	22	13	32	15	0	0	0	0	0	0	0	8.24	0	0	11.2	0.1	1
2025	11	22	13	42	15	0	0	0	0	0	0	0	8.24	0	0	11.2	0.1	1
2025	11	22	13	52	15	0	0	0	0	0	0	0	8.25	0	0	11.2	0.1	1
2025	11	22	14	2	15	0	0	0	0	0	0	0	8.26	0	0	11.4	0.1	1
2025	11	22	14	12	15	0	0	0	0	0	0	0	8.29	0	0	11.4	0.1	1
2025	11	22	14	22	15	0	0	0	0	0	0	0	8.32	0	0	11.2	0.1	1
2025	11	22	14	32	15	0	0	0	0	0	0	0	8.29	0	0	11.2	0.1	1
2025	11	22	14	42	15	0	0	0	0	0	0	0	8.3	0	0	11.4	0.1	1
2025	11	22	14	52	15	0	0	0	0	0	0	0	8.31	0	0	11.4	0.1	1
2025	11	22	15	2	15	0	0	0	0	0	0	0	8.32	0	0	11.2	0.1	1
2025	11	22	15	12	15	0	0	0	0	0	0	0	8.3	0	0	11.2	0.1	1
2025	11	22	15	22	15	0	0	0	0	0	0	0	8.29	0	0	11.2	0.1	1
2025	11	22	15	32	15	0	0	0	0	0	0	0	8.29	0	0	11.2	0.1	1
2025	11	22	15	42	15	0	0	0	0	0	0	0	8.29	0	0	11	0.1	1
2025	11	22	15	52	15	0	0	0	0	0	0	0	8.28	0	0	11	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	22	16	2	15	0	0	0	0	0	0	0	8.29	0	0	11	0.1	1
2025	11	22	16	12	15	0	0	0	0	0	0	0	8.29	0	0	11	0.1	1
2025	11	22	16	22	15	0	0	0	0	0	0	0	8.29	0	0	11	0.1	1
2025	11	22	16	32	15	0	0	0	0	0	0	0	8.29	0	0	11	0.1	1
2025	11	22	16	42	15	0	0	0	0	0	0	0	8.29	0	0	11	0.1	1
2025	11	22	16	52	15	0	0	0	0	0	0	0	8.29	0	0	11	0.1	1
2025	11	22	17	2	15	0	0	0	0	0	0	0	8.29	0	0	11	0.1	1
2025	11	22	17	12	15	0	0	0	0	0	0	0	8.28	0	0	10.8	0.1	1
2025	11	22	17	22	15	0	0	0	0	0	0	0	8.28	0	0	10.8	0.1	1
2025	11	22	17	32	15	0	0	0	0	0	0	0	8.27	0	0	10.8	0.1	1
2025	11	22	17	42	15	0	0	0	0	0	0	0	8.27	0	0	10.8	0.1	1
2025	11	22	17	52	15	0	0	0	0	0	0	0	8.26	0	0	10.8	0.1	1
2025	11	22	18	2	15	0	0	0	0	0	0	0	8.25	0	0	10.8	0.1	1
2025	11	22	18	12	15	0	0	0	0	0	0	0	8.25	0	0	10.6	0.1	1
2025	11	22	18	22	15	0	0	0	0	0	0	0	8.24	0	0	10.6	0.1	1
2025	11	22	18	32	15	0	0	0	0	0	0	0	8.25	0	0	10.6	0.1	1
2025	11	22	18	42	15	0	0	0	0	0	0	0	8.24	0	0	10.6	0.1	1
2025	11	22	18	52	15	0	0	0	0	0	0	0	8.23	0	0	10.6	0.1	1
2025	11	22	19	2	15	0	0	0	0	0	0	0	8.23	0	0	10.6	0.1	1
2025	11	22	19	12	15	0	0	0	0	0	0	0	8.23	0	0	10.6	0.1	1
2025	11	22	19	22	15	0	0	0	0	0	0	0	8.23	0	0	10.6	0.1	1
2025	11	22	19	32	15	0	0	0	0	0	0	0	8.22	0	0	10.6	0.1	1
2025	11	22	19	42	15	0	0	0	0	0	0	0	8.22	0	0	10.6	0.1	1
2025	11	22	19	52	15	0	0	0	0	0	0	0	8.21	0	0	10.6	0.1	1
2025	11	22	20	2	15	0	0	0	0	0	0	0	8.2	0	0	10.6	0.1	1
2025	11	22	20	12	15	0	0	0	0	0	0	0	8.19	0	0	10.6	0.1	1
2025	11	22	20	22	15	0	0	0	0	0	0	0	8.18	0	0	10.8	0.1	1
2025	11	22	20	32	15	0	0	0	0	0	0	0	8.18	0	0	10.8	0.1	1
2025	11	22	20	42	15	0	0	0	0	0	0	0	8.18	0	0	10.8	0.1	1
2025	11	22	20	52	15	0	0	0	0	0	0	0	8.17	0	0	10.8	0.1	1
2025	11	22	21	2	15	0	0	0	0	0	0	0	8.16	0	0	10.8	0.1	1
2025	11	22	21	12	15	0	0	0	0	0	0	0	8.16	0	0	10.8	0.1	1
2025	11	22	21	22	15	0	0	0	0	0	0	0	8.15	0	0	10.8	0.1	1
2025	11	22	21	32	15	0	0	0	0	0	0	0	8.15	0	0	10.8	0.1	1
2025	11	22	21	42	15	0	0	0	0	0	0	0	8.15	0	0	10.8	0.1	1
2025	11	22	21	52	15	0	0	0	0	0	0	0	8.14	0	0	10.8	0.1	1
2025	11	22	22	2	15	0	0	0	0	0	0	0	8.14	0	0	10.8	0.1	1
2025	11	22	22	12	15	0	0	0	0	0	0	0	8.13	0	0	10.8	0.1	1
2025	11	22	22	22	15	0	0	0	0	0	0	0	8.12	0	0	10.8	0.1	1
2025	11	22	22	32	15	0	0	0	0	0	0	0	8.12	0	0	10.8	0.1	1
2025	11	22	22	42	15	0	0	0	0	0	0	0	8.11	0	0	10.8	0.1	1
2025	11	22	22	52	15	0	0	0	0	0	0	0	8.1	0	0	10.8	0.1	1
2025	11	22	23	2	15	0	0	0	0	0	0	0	8.09	0	0	10.8	0.1	1
2025	11	22	23	12	15	0	0	0	0	0	0	0	8.08	0	0	10.8	0.1	1
2025	11	22	23	22	15	0	0	0	0	0	0	0	8.06	0	0	10.8	0.1	1
2025	11	22	23	32	15	0	0	0	0	0	0	0	8.06	0	0	10.8	0.1	1
2025	11	22	23	42	15	0	0	0	0	0	0	0	8.05	0	0	10.8	0.1	1
2025	11	22	23	52	15	0	0	0	0	0	0	0	8.04	0	0	10.8	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	23	0	2	15	0	0	0	0	0	0	0	8.03	0	0	10.8	0.1	1
2025	11	23	0	12	15	0	0	0	0	0	0	0	8.02	0	0	10.8	0.1	1
2025	11	23	0	22	15	0	0	0	0	0	0	0	8.01	0	0	10.8	0.1	1
2025	11	23	0	32	15	0	0	0	0	0	0	0	8	0	0	10.8	0.1	1
2025	11	23	0	42	15	0	0	0	0	0	0	0	7.99	0	0	10.8	0.1	1
2025	11	23	0	52	15	0	0	0	0	0	0	0	7.98	0	0	10.8	0.1	1
2025	11	23	1	2	15	0	0	0	0	0	0	0	7.97	0	0	10.8	0.1	1
2025	11	23	1	12	15	0	0	0	0	0	0	0	7.96	0	0	10.8	0.1	1
2025	11	23	1	22	15	0	0	0	0	0	0	0	7.95	0	0	10.8	0.1	1
2025	11	23	1	32	15	0	0	0	0	0	0	0	7.95	0	0	10.8	0.1	1
2025	11	23	1	42	15	0	0	0	0	0	0	0	7.93	0	0	10.8	0.1	1
2025	11	23	1	52	15	0	0	0	0	0	0	0	7.93	0	0	10.8	0.1	1
2025	11	23	2	2	15	0	0	0	0	0	0	0	7.92	0	0	10.8	0.1	1
2025	11	23	2	12	15	0	0	0	0	0	0	0	7.91	0	0	10.8	0.1	1
2025	11	23	2	22	15	0	0	0	0	0	0	0	7.91	0	0	10.8	0.1	1
2025	11	23	2	32	15	0	0	0	0	0	0	0	7.9	0	0	10.8	0.1	1
2025	11	23	2	42	15	0	0	0	0	0	0	0	7.9	0	0	10.8	0.1	1
2025	11	23	2	52	15	0	0	0	0	0	0	0	7.89	0	0	10.8	0.1	1
2025	11	23	3	2	15	0	0	0	0	0	0	0	7.89	0	0	10.8	0.1	1
2025	11	23	3	12	15	0	0	0	0	0	0	0	7.89	0	0	10.8	0.1	1
2025	11	23	3	22	15	0	0	0	0	0	0	0	7.88	0	0	10.8	0.1	1
2025	11	23	3	32	15	0	0	0	0	0	0	0	7.87	0	0	10.8	0.1	1
2025	11	23	3	42	15	0	0	0	0	0	0	0	7.87	0	0	10.8	0.1	1
2025	11	23	3	52	15	0	0	0	0	0	0	0	7.86	0	0	10.8	0.1	1
2025	11	23	4	2	15	0	0	0	0	0	0	0	7.86	0	0	10.8	0.1	1
2025	11	23	4	12	15	0	0	0	0	0	0	0	7.85	0	0	10.8	0.1	1
2025	11	23	4	22	15	0	0	0	0	0	0	0	7.84	0	0	10.8	0.1	1
2025	11	23	4	32	15	0	0	0	0	0	0	0	7.84	0	0	10.8	0.1	1
2025	11	23	4	42	15	0	0	0	0	0	0	0	7.83	0	0	10.8	0.1	1
2025	11	23	4	52	15	0	0	0	0	0	0	0	7.82	0	0	10.8	0.1	1
2025	11	23	5	2	15	0	0	0	0	0	0	0	7.82	0	0	10.8	0.1	1
2025	11	23	5	12	15	0	0	0	0	0	0	0	7.81	0	0	10.8	0.1	1
2025	11	23	5	22	15	0	0	0	0	0	0	0	7.81	0	0	10.8	0.1	1
2025	11	23	5	32	15	0	0	0	0	0	0	0	7.8	0	0	10.8	0.1	1
2025	11	23	5	42	15	0	0	0	0	0	0	0	7.79	0	0	10.8	0.1	1
2025	11	23	5	52	15	0	0	0	0	0	0	0	7.79	0	0	10.8	0.1	1
2025	11	23	6	2	15	0	0	0	0	0	0	0	7.78	0	0	10.8	0.1	1
2025	11	23	6	12	15	0	0	0	0	0	0	0	7.78	0	0	10.8	0.1	1
2025	11	23	6	22	15	0	0	0	0	0	0	0	7.77	0	0	10.8	0.1	1
2025	11	23	6	32	15	0	0	0	0	0	0	0	7.77	0	0	10.8	0.1	1
2025	11	23	6	42	15	0	0	0	0	0	0	0	7.76	0	0	10.8	0.1	1
2025	11	23	6	52	15	0	0	0	0	0	0	0	7.76	0	0	10.8	0.1	1
2025	11	23	7	2	15	0	0	0	0	0	0	0	7.75	0	0	10.8	0.1	1
2025	11	23	7	12	15	0	0	0	0	0	0	0	7.75	0	0	10.8	0.1	1
2025	11	23	7	22	15	0	0	0	0	0	0	0	7.74	0	0	10.8	0.1	1
2025	11	23	7	32	15	0	0	0	0	0	0	0	7.73	0	0	10.8	0.1	1
2025	11	23	7	42	15	0	0	0	0	0	0	0	7.73	0	0	10.8	0.1	1
2025	11	23	7	52	15	0	0	0	0	0	0	0	7.72	0	0	10.8	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	23	8	2	15	0	0	0	0	0	0	0	7.72	0	0	10.8	0.1	1
2025	11	23	8	12	15	0	0	0	0	0	0	0	7.71	0	0	11	0.1	1
2025	11	23	8	22	15	0	0	0	0	0	0	0	7.71	0	0	11.2	0.1	1
2025	11	23	8	32	15	0	0	0	0	0	0	0	7.7	0	0	11.2	0.1	1
2025	11	23	8	42	15	0	0	0	0	0	0	0	7.7	0	0	11.4	0.1	1
2025	11	23	8	52	15	0	0	0	0	0	0	0	7.7	0	0	11.6	0.1	1
2025	11	23	9	2	15	0	0	0	0	0	0	0	7.7	0	0	11.6	0.1	1
2025	11	23	9	12	15	0	0	0	0	0	0	0	7.71	0	0	11.6	0.1	1
2025	11	23	9	22	15	0	0	0	0	0	0	0	7.72	0	0	11.8	0.1	1
2025	11	23	9	32	15	0	0	0	0	0	0	0	7.74	0	0	11.8	0.1	1
2025	11	23	9	42	15	0	0	0	0	0	0	0	7.76	0	0	11.8	0.1	1
2025	11	23	9	52	15	0	0	0	0	0	0	0	7.78	0	0	11.8	0.1	1
2025	11	23	10	2	15	0	0	0	0	0	0	0	7.79	0	0	11.8	0.1	1
2025	11	23	10	12	15	0	0	0	0	0	0	0	7.81	0	0	11.8	0.1	1
2025	11	23	10	22	15	0	0	0	0	0	0	0	7.82	0	0	11.8	0.1	1
2025	11	23	10	32	15	0	0	0	0	0	0	0	7.84	0	0	11.8	0.1	1
2025	11	23	10	42	15	0	0	0	0	0	0	0	7.86	0	0	11.8	0.1	1
2025	11	23	10	52	15	0	0	0	0	0	0	0	7.88	0	0	11.8	0.1	1
2025	11	23	11	2	15	0	0	0	0	0	0	0	7.9	0	0	12	0.1	1
2025	11	23	11	12	15	0	0	0	0	0	0	0	7.92	0	0	12	0.1	1
2025	11	23	11	22	15	0	0	0	0	0	0	0	7.95	0	0	12	0.1	1
2025	11	23	11	32	15	0	0	0	0	0	0	0	7.97	0	0	12	0.1	1
2025	11	23	11	42	15	0	0	0	0	0	0	0	7.99	0	0	12	0.1	1
2025	11	23	11	52	15	0	0	0	0	0	0	0	8	0	0	12	0.1	1
2025	11	23	12	2	15	0	0	0	0	0	0	0	8.03	0	0	12	0.1	1
2025	11	23	12	12	15	0	0	0	0	0	0	0	8.05	0	0	12	0.1	1
2025	11	23	12	22	15	0	0	0	0	0	0	0	8.07	0	0	12	0.1	1
2025	11	23	12	32	15	0	0	0	0	0	0	0	8.09	0	0	12	0.1	1
2025	11	23	12	42	15	0	0	0	0	0	0	0	8.11	0	0	12	0.1	1
2025	11	23	12	52	15	0	0	0	0	0	0	0	8.12	0	0	12	0.1	1
2025	11	23	13	2	15	0	0	0	0	0	0	0	8.14	0	0	12	0.1	1
2025	11	23	13	12	15	0	0	0	0	0	0	0	8.16	0	0	11.8	0.1	1
2025	11	23	13	22	15	0	0	0	0	0	0	0	8.17	0	0	11.8	0.1	1
2025	11	23	13	32	15	0	0	0	0	0	0	0	8.19	0	0	11.8	0.1	1
2025	11	23	13	42	15	0	0	0	0	0	0	0	8.2	0	0	11.8	0.1	1
2025	11	23	13	52	15	0	0	0	0	0	0	0	8.21	0	0	11.8	0.1	1
2025	11	23	14	2	15	0	0	0	0	0	0	0	8.22	0	0	11.8	0.1	1
2025	11	23	14	12	15	0	0	0	0	0	0	0	8.23	0	0	11.8	0.1	1
2025	11	23	14	22	15	0	0	0	0	0	0	0	8.24	0	0	11.8	0.1	1
2025	11	23	14	32	15	0	0	0	0	0	0	0	8.24	0	0	11.8	0.1	1
2025	11	23	14	42	15	0	0	0	0	0	0	0	8.24	0	0	11.8	0.1	1
2025	11	23	14	52	15	0	0	0	0	0	0	0	8.24	0	0	11.8	0.1	1
2025	11	23	15	2	15	0	0	0	0	0	0	0	8.25	0	0	11.8	0.1	1
2025	11	23	15	12	15	0	0	0	0	0	0	0	8.25	0	0	11.6	0.1	1
2025	11	23	15	22	15	0	0	0	0	0	0	0	8.25	0	0	11.6	0.1	1
2025	11	23	15	32	15	0	0	0	0	0	0	0	8.25	0	0	11.6	0.1	1
2025	11	23	15	42	15	0	0	0	0	0	0	0	8.24	0	0	11.6	0.1	1
2025	11	23	15	52	15	0	0	0	0	0	0	0	8.24	0	0	11.6	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	23	16	2	15	0	0	0	0	0	0	0	8.23	0	0	11.6	0.1	1
2025	11	23	16	12	15	0	0	0	0	0	0	0	8.22	0	0	11.6	0.1	1
2025	11	23	16	22	15	0	0	0	0	0	0	0	8.21	0	0	11.4	0.1	1
2025	11	23	16	32	15	0	0	0	0	0	0	0	8.21	0	0	11.4	0.1	1
2025	11	23	16	42	15	0	0	0	0	0	0	0	8.21	0	0	11.4	0.1	1
2025	11	23	16	52	15	0	0	0	0	0	0	0	8.21	0	0	11.4	0.1	1
2025	11	23	17	2	15	0	0	0	0	0	0	0	8.21	0	0	11.2	0.1	1
2025	11	23	17	12	15	0	0	0	0	0	0	0	8.21	0	0	11.2	0.1	1
2025	11	23	17	22	15	0	0	0	0	0	0	0	8.2	0	0	11.2	0.1	1
2025	11	23	17	32	15	0	0	0	0	0	0	0	8.2	0	0	11.2	0.1	1
2025	11	23	17	42	15	0	0	0	0	0	0	0	8.2	0	0	11.2	0.1	1
2025	11	23	17	52	15	0	0	0	0	0	0	0	8.19	0	0	11.2	0.1	1
2025	11	23	18	2	15	0	0	0	0	0	0	0	8.19	0	0	11.2	0.1	1
2025	11	23	18	12	15	0	0	0	0	0	0	0	8.18	0	0	11.2	0.1	1
2025	11	23	18	22	15	0	0	0	0	0	0	0	8.17	0	0	11.2	0.1	1
2025	11	23	18	32	15	0	0	0	0	0	0	0	8.16	0	0	11.2	0.1	1
2025	11	23	18	42	15	0	0	0	0	0	0	0	8.16	0	0	11.2	0.1	1
2025	11	23	18	52	15	0	0	0	0	0	0	0	8.14	0	0	11.2	0.1	1
2025	11	23	19	2	15	0	0	0	0	0	0	0	8.13	0	0	11.2	0.1	1
2025	11	23	19	12	15	0	0	0	0	0	0	0	8.11	0	0	11.2	0.1	1
2025	11	23	19	22	15	0	0	0	0	0	0	0	8.1	0	0	11.2	0.1	1
2025	11	23	19	32	15	0	0	0	0	0	0	0	8.08	0	0	11	0.1	1
2025	11	23	19	42	15	0	0	0	0	0	0	0	8.06	0	0	11.2	0.1	1
2025	11	23	19	52	15	0	0	0	0	0	0	0	8.04	0	0	11.2	0.1	1
2025	11	23	20	2	15	0	0	0	0	0	0	0	8.03	0	0	11.2	0.1	1
2025	11	23	20	12	15	0	0	0	0	0	0	0	8.02	0	0	11.2	0.1	1
2025	11	23	20	22	15	0	0	0	0	0	0	0	8	0	0	11.2	0.1	1
2025	11	23	20	32	15	0	0	0	0	0	0	0	7.98	0	0	11.2	0.1	1
2025	11	23	20	42	15	0	0	0	0	0	0	0	7.96	0	0	11.2	0.1	1
2025	11	23	20	52	15	0	0	0	0	0	0	0	7.94	0	0	11.2	0.1	1
2025	11	23	21	2	15	0	0	0	0	0	0	0	7.92	0	0	11.2	0.1	1
2025	11	23	21	12	15	0	0	0	0	0	0	0	7.9	0	0	11.2	0.1	1
2025	11	23	21	22	15	0	0	0	0	0	0	0	7.88	0	0	11.2	0.1	1
2025	11	23	21	32	15	0	0	0	0	0	0	0	7.86	0	0	11.2	0.1	1
2025	11	23	21	42	15	0	0	0	0	0	0	0	7.84	0	0	11.2	0.1	1
2025	11	23	21	52	15	0	0	0	0	0	0	0	7.82	0	0	11.2	0.1	1
2025	11	23	22	2	15	0	0	0	0	0	0	0	7.8	0	0	11.2	0.1	1
2025	11	23	22	12	15	0	0	0	0	0	0	0	7.78	0	0	11.2	0.1	1
2025	11	23	22	22	15	0	0	0	0	0	0	0	7.76	0	0	11.2	0.1	1
2025	11	23	22	32	15	0	0	0	0	0	0	0	7.74	0	0	11.2	0.1	1
2025	11	23	22	42	15	0	0	0	0	0	0	0	7.71	0	0	11.2	0.1	1
2025	11	23	22	52	15	0	0	0	0	0	0	0	7.69	0	0	11.2	0.1	1
2025	11	23	23	2	15	0	0	0	0	0	0	0	7.67	0	0	11.2	0.1	1
2025	11	23	23	12	15	0	0	0	0	0	0	0	7.65	0	0	11.2	0.1	1
2025	11	23	23	22	15	0	0	0	0	0	0	0	7.63	0	0	11.2	0.1	1
2025	11	23	23	32	15	0	0	0	0	0	0	0	7.62	0	0	11.2	0.1	1
2025	11	23	23	42	15	0	0	0	0	0	0	0	7.6	0	0	11.2	0.1	1
2025	11	23	23	52	15	0	0	0	0	0	0	0	7.58	0	0	11.2	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	24	0	2	15	0	0	0	0	0	0	0	7.57	0	0	11.2	0.1	1
2025	11	24	0	12	15	0	0	0	0	0	0	0	7.55	0	0	11.2	0.1	1
2025	11	24	0	22	15	0	0	0	0	0	0	0	7.54	0	0	11.2	0.1	1
2025	11	24	0	32	15	0	0	0	0	0	0	0	7.52	0	0	11.2	0.1	1
2025	11	24	0	42	15	0	0	0	0	0	0	0	7.5	0	0	11.2	0.1	1
2025	11	24	0	52	15	0	0	0	0	0	0	0	7.49	0	0	11.2	0.1	1
2025	11	24	1	2	15	0	0	0	0	0	0	0	7.48	0	0	11	0.1	1
2025	11	24	1	12	15	0	0	0	0	0	0	0	7.47	0	0	11	0.1	1
2025	11	24	1	22	15	0	0	0	0	0	0	0	7.46	0	0	11	0.1	1
2025	11	24	1	32	15	0	0	0	0	0	0	0	7.45	0	0	11	0.1	1
2025	11	24	1	42	15	0	0	0	0	0	0	0	7.44	0	0	11	0.1	1
2025	11	24	1	52	15	0	0	0	0	0	0	0	7.43	0	0	11	0.1	1
2025	11	24	2	2	15	0	0	0	0	0	0	0	7.42	0	0	11	0.1	1
2025	11	24	2	12	15	0	0	0	0	0	0	0	7.41	0	0	11	0.1	1
2025	11	24	2	22	15	0	0	0	0	0	0	0	7.41	0	0	11	0.1	1
2025	11	24	2	32	15	0	0	0	0	0	0	0	7.41	0	0	11	0.1	1
2025	11	24	2	42	15	0	0	0	0	0	0	0	7.4	0	0	11	0.1	1
2025	11	24	2	52	15	0	0	0	0	0	0	0	7.39	0	0	11	0.1	1
2025	11	24	3	2	15	0	0	0	0	0	0	0	7.39	0	0	11	0.1	1
2025	11	24	3	12	15	0	0	0	0	0	0	0	7.38	0	0	11	0.1	1
2025	11	24	3	22	15	0	0	0	0	0	0	0	7.38	0	0	11	0.1	1
2025	11	24	3	32	15	0	0	0	0	0	0	0	7.37	0	0	11	0.1	1
2025	11	24	3	42	15	0	0	0	0	0	0	0	7.37	0	0	11	0.1	1
2025	11	24	3	52	15	0	0	0	0	0	0	0	7.37	0	0	11	0.1	1
2025	11	24	4	2	15	0	0	0	0	0	0	0	7.36	0	0	11	0.1	1
2025	11	24	4	12	15	0	0	0	0	0	0	0	7.36	0	0	11	0.1	1
2025	11	24	4	22	15	0	0	0	0	0	0	0	7.35	0	0	11	0.1	1
2025	11	24	4	32	15	0	0	0	0	0	0	0	7.35	0	0	11	0.1	1
2025	11	24	4	42	15	0	0	0	0	0	0	0	7.35	0	0	11	0.1	1
2025	11	24	4	52	15	0	0	0	0	0	0	0	7.34	0	0	11	0.1	1
2025	11	24	5	2	15	0	0	0	0	0	0	0	7.33	0	0	11	0.1	1
2025	11	24	5	12	15	0	0	0	0	0	0	0	7.33	0	0	11	0.1	1
2025	11	24	5	22	15	0	0	0	0	0	0	0	7.33	0	0	11	0.1	1
2025	11	24	5	32	15	0	0	0	0	0	0	0	7.33	0	0	11	0.1	1
2025	11	24	5	42	15	0	0	0	0	0	0	0	7.32	0	0	11	0.1	1
2025	11	24	5	52	15	0	0	0	0	0	0	0	7.32	0	0	11	0.1	1
2025	11	24	6	2	15	0	0	0	0	0	0	0	7.31	0	0	11	0.1	1
2025	11	24	6	12	15	0	0	0	0	0	0	0	7.31	0	0	11	0.1	1
2025	11	24	6	22	15	0	0	0	0	0	0	0	7.31	0	0	11	0.1	1
2025	11	24	6	32	15	0	0	0	0	0	0	0	7.31	0	0	11	0.1	1
2025	11	24	6	42	15	0	0	0	0	0	0	0	7.3	0	0	11	0.1	1
2025	11	24	6	52	15	0	0	0	0	0	0	0	7.3	0	0	11	0.1	1
2025	11	24	7	2	15	0	0	0	0	0	0	0	7.29	0	0	11	0.1	1
2025	11	24	7	12	15	0	0	0	0	0	0	0	7.29	0	0	11	0.1	1
2025	11	24	7	22	15	0	0	0	0	0	0	0	7.28	0	0	11	0.1	1
2025	11	24	7	32	15	0	0	0	0	0	0	0	7.29	0	0	11	0.1	1
2025	11	24	7	42	15	0	0	0	0	0	0	0	7.28	0	0	11	0.1	1
2025	11	24	7	52	15	0	0	0	0	0	0	0	7.28	0	0	11	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	24	8	2	15	0	0	0	0	0	0	0	7.28	0	0	11	0.1	1
2025	11	24	8	12	15	0	0	0	0	0	0	0	7.28	0	0	11	0.1	1
2025	11	24	8	22	15	0	0	0	0	0	0	0	7.28	0	0	11.2	0.1	1
2025	11	24	8	32	15	0	0	0	0	0	0	0	7.28	0	0	11.2	0.1	1
2025	11	24	8	42	15	0	0	0	0	0	0	0	7.28	0	0	11.4	0.1	1
2025	11	24	8	52	15	0	0	0	0	0	0	0	7.28	0	0	11.6	0.1	1
2025	11	24	9	2	15	0	0	0	0	0	0	0	7.29	0	0	11.8	0.1	1
2025	11	24	9	12	15	0	0	0	0	0	0	0	7.3	0	0	11.8	0.1	1
2025	11	24	9	22	15	0	0	0	0	0	0	0	7.32	0	0	12	0.1	1
2025	11	24	9	32	15	0	0	0	0	0	0	0	7.34	0	0	12	0.1	1
2025	11	24	9	42	15	0	0	0	0	0	0	0	7.37	0	0	12.2	0.1	1
2025	11	24	9	52	15	0	0	0	0	0	0	0	7.4	0	0	12	0.1	1
2025	11	24	10	2	15	0	0	0	0	0	0	0	7.42	0	0	11.8	0.1	1
2025	11	24	10	12	15	0	0	0	0	0	0	0	7.44	0	0	11.6	0.1	1
2025	11	24	10	22	15	0	0	0	0	0	0	0	7.47	0	0	12	0.1	1
2025	11	24	10	32	15	0	0	0	0	0	0	0	7.5	0	0	12	0.1	1
2025	11	24	10	42	15	0	0	0	0	0	0	0	7.52	0	0	11.8	0.1	1
2025	11	24	10	52	15	0	0	0	0	0	0	0	7.55	0	0	11.8	0.1	1
2025	11	24	11	2	15	0	0	0	0	0	0	0	7.57	0	0	11.8	0.1	1
2025	11	24	11	12	15	0	0	0	0	0	0	0	7.59	0	0	11.8	0.1	1
2025	11	24	11	22	15	0	0	0	0	0	0	0	7.62	0	0	11.8	0.1	1
2025	11	24	11	32	15	0	0	0	0	0	0	0	7.64	0	0	11.8	0.1	1
2025	11	24	11	42	15	0	0	0	0	0	0	0	7.66	0	0	11.8	0.1	1
2025	11	24	11	52	15	0	0	0	0	0	0	0	7.69	0	0	11.8	0.1	1
2025	11	24	12	2	15	0	0	0	0	0	0	0	7.72	0	0	12.4	0.1	1
2025	11	24	12	12	15	0	0	0	0	0	0	0	7.74	0	0	14	0.1	1
2025	11	24	12	22	15	0	0	0	0	0	0	0	7.76	0	0	14.2	0.1	1
2025	11	24	12	32	15	0	0	0	0	0	0	0	7.78	0	0	11.8	0.1	1
2025	11	24	12	42	15	0	0	0	0	0	0	0	7.8	0	0	12	0.1	1
2025	11	24	12	52	15	0	0	0	0	0	0	0	7.82	0	0	12	0.1	1
2025	11	24	13	2	15	0	0	0	0	0	0	0	7.84	0	0	12	0.1	1
2025	11	24	13	12	15	0	0	0	0	0	0	0	7.85	0	0	12	0.1	1
2025	11	24	13	22	15	0	0	0	0	0	0	0	7.87	0	0	12	0.1	1
2025	11	24	13	32	15	0	0	0	0	0	0	0	7.88	0	0	11.8	0.1	1
2025	11	24	13	42	15	0	0	0	0	0	0	0	7.9	0	0	11.8	0.1	1
2025	11	24	13	52	15	0	0	0	0	0	0	0	7.9	0	0	11.6	0.1	1
2025	11	24	14	2	15	0	0	0	0	0	0	0	7.92	0	0	11.8	0.1	1
2025	11	24	14	12	15	0	0	0	0	0	0	0	7.92	0	0	11.8	0.1	1
2025	11	24	14	22	15	0	0	0	0	0	0	0	7.93	0	0	11.8	0.1	1
2025	11	24	14	32	15	0	0	0	0	0	0	0	7.93	0	0	11.6	0.1	1
2025	11	24	14	42	15	0	0	0	0	0	0	0	7.93	0	0	11.6	0.1	1
2025	11	24	14	52	15	0	0	0	0	0	0	0	7.94	0	0	11.4	0.1	1
2025	11	24	15	2	15	0	0	0	0	0	0	0	7.94	0	0	11.4	0.1	1
2025	11	24	15	12	15	0	0	0	0	0	0	0	7.93	0	0	11.4	0.1	1
2025	11	24	15	22	15	0	0	0	0	0	0	0	7.93	0	0	11.4	0.1	1
2025	11	24	15	32	15	0	0	0	0	0	0	0	7.92	0	0	11.4	0.1	1
2025	11	24	15	42	15	0	0	0	0	0	0	0	7.92	0	0	11.2	0.1	1
2025	11	24	15	52	15	0	0	0	0	0	0	0	7.91	0	0	11.2	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	24	16	2	15	0	0	0	0	0	0	0	7.91	0	0	11.4	0.1	1
2025	11	24	16	12	15	0	0	0	0	0	0	0	7.88	0	0	11.4	0.1	1
2025	11	24	16	22	15	0	0	0	0	0	0	0	7.88	0	0	11.4	0.1	1
2025	11	24	16	32	15	0	0	0	0	0	0	0	7.87	0	0	11.4	0.1	1
2025	11	24	16	42	15	0	0	0	0	0	0	0	7.87	0	0	11.4	0.1	1
2025	11	24	16	52	15	0	0	0	0	0	0	0	7.86	0	0	11.2	0.1	1
2025	11	24	17	2	15	0	0	0	0	0	0	0	7.85	0	0	11	0.1	1
2025	11	24	17	12	15	0	0	0	0	0	0	0	7.85	0	0	11.2	0.1	1
2025	11	24	17	22	15	0	0	0	0	0	0	0	7.84	0	0	11.2	0.1	1
2025	11	24	17	32	15	0	0	0	0	0	0	0	7.84	0	0	11.2	0.1	1
2025	11	24	17	42	15	0	0	0	0	0	0	0	7.83	0	0	11.2	0.1	1
2025	11	24	17	52	15	0	0	0	0	0	0	0	7.82	0	0	11	0.1	1
2025	11	24	18	2	15	0	0	0	0	0	0	0	7.82	0	0	11	0.1	1
2025	11	24	18	12	15	0	0	0	0	0	0	0	7.8	0	0	10.8	0.1	1
2025	11	24	18	22	15	0	0	0	0	0	0	0	7.79	0	0	10.8	0.1	1
2025	11	24	18	32	15	0	0	0	0	0	0	0	7.78	0	0	10.8	0.1	1
2025	11	24	18	42	15	0	0	0	0	0	0	0	7.76	0	0	10.8	0.1	1
2025	11	24	18	52	15	0	0	0	0	0	0	0	7.75	0	0	10.8	0.1	1
2025	11	24	19	2	15	0	0	0	0	0	0	0	7.73	0	0	10.8	0.1	1
2025	11	24	19	12	15	0	0	0	0	0	0	0	7.71	0	0	10.8	0.1	1
2025	11	24	19	22	15	0	0	0	0	0	0	0	7.69	0	0	11	0.1	1
2025	11	24	19	32	15	0	0	0	0	0	0	0	7.67	0	0	11.2	0.1	1
2025	11	24	19	42	15	0	0	0	0	0	0	0	7.65	0	0	11.2	0.1	1
2025	11	24	19	52	15	0	0	0	0	0	0	0	7.63	0	0	11.2	0.1	1
2025	11	24	20	2	15	0	0	0	0	0	0	0	7.61	0	0	11.2	0.1	1
2025	11	24	20	12	15	0	0	0	0	0	0	0	7.58	0	0	11.2	0.1	1
2025	11	24	20	22	15	0	0	0	0	0	0	0	7.56	0	0	11.2	0.1	1
2025	11	24	20	32	15	0	0	0	0	0	0	0	7.53	0	0	11.2	0.1	1
2025	11	24	20	42	15	0	0	0	0	0	0	0	7.51	0	0	11.2	0.1	1
2025	11	24	20	52	15	0	0	0	0	0	0	0	7.49	0	0	11.2	0.1	1
2025	11	24	21	2	15	0	0	0	0	0	0	0	7.46	0	0	11.2	0.1	1
2025	11	24	21	12	15	0	0	0	0	0	0	0	7.44	0	0	11.2	0.1	1
2025	11	24	21	22	15	0	0	0	0	0	0	0	7.41	0	0	11.2	0.1	1
2025	11	24	21	32	15	0	0	0	0	0	0	0	7.38	0	0	11.2	0.1	1
2025	11	24	21	42	15	0	0	0	0	0	0	0	7.36	0	0	11.2	0.1	1
2025	11	24	21	52	15	0	0	0	0	0	0	0	7.34	0	0	11.2	0.1	1
2025	11	24	22	2	15	0	0	0	0	0	0	0	7.31	0	0	11.2	0.1	1
2025	11	24	22	12	15	0	0	0	0	0	0	0	7.28	0	0	11.2	0.1	1
2025	11	24	22	22	15	0	0	0	0	0	0	0	7.26	0	0	11.2	0.1	1
2025	11	24	22	32	15	0	0	0	0	0	0	0	7.24	0	0	11.2	0.1	1
2025	11	24	22	42	15	0	0	0	0	0	0	0	7.21	0	0	11.2	0.1	1
2025	11	24	22	52	15	0	0	0	0	0	0	0	7.18	0	0	11.2	0.1	1
2025	11	24	23	2	15	0	0	0	0	0	0	0	7.16	0	0	11.2	0.1	1
2025	11	24	23	12	15	0	0	0	0	0	0	0	7.14	0	0	11.2	0.1	1
2025	11	24	23	22	15	0	0	0	0	0	0	0	7.12	0	0	11.2	0.1	1
2025	11	24	23	32	15	0	0	0	0	0	0	0	7.1	0	0	11.2	0.1	1
2025	11	24	23	42	15	0	0	0	0	0	0	0	7.07	0	0	11.2	0.1	1
2025	11	24	23	52	15	0	0	0	0	0	0	0	7.06	0	0	11.2	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	25	0	2	15	0	0	0	0	0	0	0	7.03	0	0	11.2	0.1	1
2025	11	25	0	12	15	0	0	0	0	0	0	0	7.02	0	0	11.2	0.1	1
2025	11	25	0	22	15	0	0	0	0	0	0	0	7	0	0	11.2	0.1	1
2025	11	25	0	32	15	0	0	0	0	0	0	0	6.98	0	0	11.2	0.1	1
2025	11	25	0	42	15	0	0	0	0	0	0	0	6.96	0	0	11.2	0.1	1
2025	11	25	0	52	15	0	0	0	0	0	0	0	6.95	0	0	11.2	0.1	1
2025	11	25	1	2	15	0	0	0	0	0	0	0	6.93	0	0	11.2	0.1	1
2025	11	25	1	12	15	0	0	0	0	0	0	0	6.92	0	0	11.2	0.1	1
2025	11	25	1	22	15	0	0	0	0	0	0	0	6.91	0	0	11.2	0.1	1
2025	11	25	1	32	15	0	0	0	0	0	0	0	6.9	0	0	11.2	0.1	1
2025	11	25	1	42	15	0	0	0	0	0	0	0	6.88	0	0	11.2	0.1	1
2025	11	25	1	52	15	0	0	0	0	0	0	0	6.88	0	0	11.2	0.1	1
2025	11	25	2	2	15	0	0	0	0	0	0	0	6.86	0	0	11.2	0.1	1
2025	11	25	2	12	15	0	0	0	0	0	0	0	6.86	0	0	11.2	0.1	1
2025	11	25	2	22	15	0	0	0	0	0	0	0	6.86	0	0	11.2	0.1	1
2025	11	25	2	32	15	0	0	0	0	0	0	0	6.85	0	0	11.2	0.1	1
2025	11	25	2	42	15	0	0	0	0	0	0	0	6.84	0	0	11.2	0.1	1
2025	11	25	2	52	15	0	0	0	0	0	0	0	6.84	0	0	11.2	0.1	1
2025	11	25	3	2	15	0	0	0	0	0	0	0	6.84	0	0	11.2	0.1	1
2025	11	25	3	12	15	0	0	0	0	0	0	0	6.84	0	0	11.2	0.1	1
2025	11	25	3	22	15	0	0	0	0	0	0	0	6.83	0	0	11	0.1	1
2025	11	25	3	32	15	0	0	0	0	0	0	0	6.83	0	0	11	0.1	1
2025	11	25	3	42	15	0	0	0	0	0	0	0	6.83	0	0	11	0.1	1
2025	11	25	3	52	15	0	0	0	0	0	0	0	6.83	0	0	11	0.1	1
2025	11	25	4	2	15	0	0	0	0	0	0	0	6.82	0	0	11	0.1	1
2025	11	25	4	12	15	0	0	0	0	0	0	0	6.82	0	0	11	0.1	1
2025	11	25	4	22	15	0	0	0	0	0	0	0	6.82	0	0	11	0.1	1
2025	11	25	4	32	15	0	0	0	0	0	0	0	6.82	0	0	11	0.1	1
2025	11	25	4	42	15	0	0	0	0	0	0	0	6.82	0	0	11	0.1	1
2025	11	25	4	52	15	0	0	0	0	0	0	0	6.81	0	0	11	0.1	1
2025	11	25	5	2	15	0	0	0	0	0	0	0	6.81	0	0	11	0.1	1
2025	11	25	5	12	15	0	0	0	0	0	0	0	6.82	0	0	11	0.1	1
2025	11	25	5	22	15	0	0	0	0	0	0	0	6.81	0	0	11	0.1	1
2025	11	25	5	32	15	0	0	0	0	0	0	0	6.81	0	0	11	0.1	1
2025	11	25	5	42	15	0	0	0	0	0	0	0	6.8	0	0	11	0.1	1
2025	11	25	5	52	15	0	0	0	0	0	0	0	6.8	0	0	11	0.1	1
2025	11	25	6	2	15	0	0	0	0	0	0	0	6.79	0	0	11	0.1	1
2025	11	25	6	12	15	0	0	0	0	0	0	0	6.8	0	0	11	0.1	1
2025	11	25	6	22	15	0	0	0	0	0	0	0	6.8	0	0	11	0.1	1
2025	11	25	6	32	15	0	0	0	0	0	0	0	6.79	0	0	11	0.1	1
2025	11	25	6	42	15	0	0	0	0	0	0	0	6.79	0	0	11	0.1	1
2025	11	25	6	52	15	0	0	0	0	0	0	0	6.79	0	0	11	0.1	1
2025	11	25	7	2	15	0	0	0	0	0	0	0	6.78	0	0	11	0.1	1
2025	11	25	7	12	15	0	0	0	0	0	0	0	6.78	0	0	11	0.1	1
2025	11	25	7	22	15	0	0	0	0	0	0	0	6.78	0	0	11	0.1	1
2025	11	25	7	32	15	0	0	0	0	0	0	0	6.79	0	0	11	0.1	1
2025	11	25	7	42	15	0	0	0	0	0	0	0	6.79	0	0	11	0.1	1
2025	11	25	7	52	15	0	0	0	0	0	0	0	6.79	0	0	11	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	25	8	2	15	0	0	0	0	0	0	0	6.79	0	0	11	0.1	1
2025	11	25	8	12	15	0	0	0	0	0	0	0	6.79	0	0	11.2	0.1	1
2025	11	25	8	22	15	0	0	0	0	0	0	0	6.79	0	0	11.4	0.1	1
2025	11	25	8	32	15	0	0	0	0	0	0	0	6.8	0	0	11.4	0.1	1
2025	11	25	8	42	15	0	0	0	0	0	0	0	6.8	0	0	11.6	0.1	1
2025	11	25	8	52	15	0	0	0	0	0	0	0	6.81	0	0	11.8	0.1	1
2025	11	25	9	2	15	0	0	0	0	0	0	0	6.82	0	0	11.8	0.1	1
2025	11	25	9	12	15	0	0	0	0	0	0	0	6.83	0	0	11.8	0.1	1
2025	11	25	9	22	15	0	0	0	0	0	0	0	6.85	0	0	12	0.1	1
2025	11	25	9	32	15	0	0	0	0	0	0	0	6.88	0	0	12	0.1	1
2025	11	25	9	42	15	0	0	0	0	0	0	0	6.91	0	0	12	0.1	1
2025	11	25	9	52	15	0	0	0	0	0	0	0	6.94	0	0	11.6	0.1	1
2025	11	25	10	2	15	0	0	0	0	0	0	0	6.96	0	0	11.6	0.1	1
2025	11	25	10	12	15	0	0	0	0	0	0	0	7	0	0	11.8	0.1	1
2025	11	25	10	22	15	0	0	0	0	0	0	0	7.02	0	0	11.6	0.1	1
2025	11	25	10	32	15	0	0	0	0	0	0	0	7.05	0	0	11.6	0.1	1
2025	11	25	10	42	15	0	0	0	0	0	0	0	7.07	0	0	11.6	0.1	1
2025	11	25	10	52	15	0	0	0	0	0	0	0	7.1	0	0	11.6	0.1	1
2025	11	25	11	2	15	0	0	0	0	0	0	0	7.13	0	0	11.6	0.1	1
2025	11	25	11	12	15	0	0	0	0	0	0	0	7.15	0	0	11.6	0.1	1
2025	11	25	11	22	15	0	0	0	0	0	0	0	7.18	0	0	11.6	0.1	1
2025	11	25	11	32	15	0	0	0	0	0	0	0	7.21	0	0	11.6	0.1	1
2025	11	25	11	42	15	0	0	0	0	0	0	0	7.23	0	0	11.6	0.1	1
2025	11	25	11	52	15	0	0	0	0	0	0	0	7.25	0	0	11.6	0.1	1
2025	11	25	12	2	15	0	0	0	0	0	0	0	7.27	0	0	11.6	0.1	1
2025	11	25	12	12	15	0	0	0	0	0	0	0	7.3	0	0	11.6	0.1	1
2025	11	25	12	28	1	0	0	0	0	0	0	0	7.33	0	0	11.6	0.1	1
2025	11	25	12	38	1	0	0	0	0	0	0	0	7.35	0	0	11.6	0.1	1
2025	11	25	12	48	1	0	0	0	0	0	0	0	7.36	0	0	11.6	0.1	1
2025	11	25	12	58	1	0	0	0	0	0	0	0	7.38	0	0	11.6	0.1	1
2025	11	25	13	8	1	0	0	0	0	0	0	0	7.4	0	0	11.6	0.1	1
2025	11	25	13	18	1	0	0	0	0	0	0	0	7.42	0	0	11.6	0.1	1
2025	11	25	13	28	1	0	0	0	0	0	0	0	7.43	0	0	11.6	0.1	1
2025	11	25	13	38	1	0	0	0	0	0	0	0	7.44	0	0	11.6	0.1	1
2025	11	25	13	48	1	0	0	0	0	0	0	0	7.45	0	0	11.4	0.1	1
2025	11	25	13	58	1	0	0	0	0	0	0	0	7.46	0	0	11.4	0.1	1
2025	11	25	14	8	1	0	0	0	0	0	0	0	7.46	0	0	11.4	0.1	1
2025	11	25	14	18	1	0	0	0	0	0	0	0	7.47	0	0	11.4	0.1	1
2025	11	25	14	28	1	0	0	0	0	0	0	0	7.48	0	0	11.4	0.1	1
2025	11	25	14	38	1	0	0	0	0	0	0	0	7.48	0	0	11.4	0.1	1
2025	11	25	14	48	1	0	0	0	0	0	0	0	7.49	0	0	11.4	0.1	1
2025	11	25	14	58	1	0	0	0	0	0	0	0	7.48	0	0	11.4	0.1	1
2025	11	25	15	8	1	0	0	0	0	0	0	0	7.48	0	0	11.4	0.1	1
2025	11	25	15	18	1	0	0	0	0	0	0	0	7.48	0	0	11.2	0.1	1
2025	11	25	15	28	1	0	0	0	0	0	0	0	7.47	0	0	11.2	0.1	1
2025	11	25	15	38	1	0	0	0	0	0	0	0	7.46	0	0	11.2	0.1	1
2025	11	25	15	48	1	0	0	0	0	0	0	0	7.45	0	0	11.2	0.1	1
2025	11	25	15	58	1	0	0	0	0	0	0	0	7.44	0	0	11.2	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	25	16	8	1	0	0	0	0	0	0	0	7.43	0	0	11	0.1	1
2025	11	25	16	18	1	0	0	0	0	0	0	0	7.41	0	0	11	0.1	1
2025	11	25	16	28	1	0	0	0	0	0	0	0	7.41	0	0	11	0.1	1
2025	11	25	16	38	1	0	0	0	0	0	0	0	7.39	0	0	11	0.1	1
2025	11	25	16	48	1	0	0	0	0	0	0	0	7.39	0	0	10.8	0.1	1
2025	11	25	16	58	1	0	0	0	0	0	0	0	7.38	0	0	10.8	0.1	1
2025	11	25	17	8	1	0	0	0	0	0	0	0	7.38	0	0	10.8	0.1	1
2025	11	25	17	18	1	0	0	0	0	0	0	0	7.37	0	0	10.8	0.1	1
2025	11	25	17	28	1	0	0	0	0	0	0	0	7.36	0	0	10.8	0.1	1
2025	11	25	17	38	1	0	0	0	0	0	0	0	7.35	0	0	10.8	0.1	1
2025	11	25	17	48	1	0	0	0	0	0	0	0	7.34	0	0	10.8	0.1	1
2025	11	25	17	58	1	0	0	0	0	0	0	0	7.33	0	0	10.6	0.1	1
2025	11	25	18	8	1	0	0	0	0	0	0	0	7.32	0	0	10.6	0.1	1
2025	11	25	18	18	1	0	0	0	0	0	0	0	7.31	0	0	10.6	0.1	1
2025	11	25	18	28	1	0	0	0	0	0	0	0	7.3	0	0	10.6	0.1	1
2025	11	25	18	38	1	0	0	0	0	0	0	0	7.28	0	0	10.6	0.1	1
2025	11	25	18	48	1	0	0	0	0	0	0	0	7.26	0	0	10.6	0.1	1
2025	11	25	18	58	1	0	0	0	0	0	0	0	7.24	0	0	10.6	0.1	1
2025	11	25	19	8	1	0	0	0	0	0	0	0	7.23	0	0	10.6	0.1	1
2025	11	25	19	18	1	0	0	0	0	0	0	0	7.2	0	0	10.6	0.1	1
2025	11	25	19	28	1	0	0	0	0	0	0	0	7.19	0	0	10.6	0.1	1
2025	11	25	19	38	1	0	0	0	0	0	0	0	7.16	0	0	10.6	0.1	1
2025	11	25	19	48	1	0	0	0	0	0	0	0	7.14	0	0	11	0.1	1
2025	11	25	19	58	1	0	0	0	0	0	0	0	7.11	0	0	10.6	0.1	1
2025	11	25	20	8	1	0	0	0	0	0	0	0	7.09	0	0	10.6	0.1	1
2025	11	25	20	18	1	0	0	0	0	0	0	0	7.07	0	0	10.6	0.1	1
2025	11	25	20	28	1	0	0	0	0	0	0	0	7.04	0	0	10.6	0.1	1
2025	11	25	20	38	1	0	0	0	0	0	0	0	7.02	0	0	10.6	0.1	1
2025	11	25	20	48	1	0	0	0	0	0	0	0	7	0	0	10.6	0.1	1
2025	11	25	20	58	1	0	0	0	0	0	0	0	6.97	0	0	10.6	0.1	1
2025	11	25	21	8	1	0	0	0	0	0	0	0	6.94	0	0	10.6	0.1	1
2025	11	25	21	18	1	0	0	0	0	0	0	0	6.92	0	0	10.6	0.1	1
2025	11	25	21	28	1	0	0	0	0	0	0	0	6.89	0	0	10.6	0.1	1
2025	11	25	21	38	1	0	0	0	0	0	0	0	6.87	0	0	10.6	0.1	1
2025	11	25	21	48	1	0	0	0	0	0	0	0	6.85	0	0	10.6	0.1	1
2025	11	25	21	58	1	0	0	0	0	0	0	0	6.82	0	0	10.6	0.1	1
2025	11	25	22	8	1	0	0	0	0	0	0	0	6.8	0	0	10.6	0.1	1
2025	11	25	22	18	1	0	0	0	0	0	0	0	6.77	0	0	10.6	0.1	1
2025	11	25	22	28	1	0	0	0	0	0	0	0	6.75	0	0	10.6	0.1	1
2025	11	25	22	38	1	0	0	0	0	0	0	0	6.73	0	0	10.6	0.1	1
2025	11	25	22	48	1	0	0	0	0	0	0	0	6.71	0	0	10.6	0.1	1
2025	11	25	22	58	1	0	0	0	0	0	0	0	6.68	0	0	10.6	0.1	1
2025	11	25	23	8	1	0	0	0	0	0	0	0	6.66	0	0	10.6	0.1	1
2025	11	25	23	18	1	0	0	0	0	0	0	0	6.64	0	0	10.6	0.1	1
2025	11	25	23	28	1	0	0	0	0	0	0	0	6.62	0	0	10.6	0.1	1
2025	11	25	23	38	1	0	0	0	0	0	0	0	6.6	0	0	10.6	0.1	1
2025	11	25	23	48	1	0	0	0	0	0	0	0	6.57	0	0	10.6	0.1	1
2025	11	25	23	58	1	0	0	0	0	0	0	0	6.55	0	0	10.6	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	26	0	8	1	0	0	0	0	0	0	0	6.54	0	0	10.6	0.1	1
2025	11	26	0	18	1	0	0	0	0	0	0	0	6.52	0	0	10.6	0.1	1
2025	11	26	0	28	1	0	0	0	0	0	0	0	6.5	0	0	10.6	0.1	1
2025	11	26	0	38	1	0	0	0	0	0	0	0	6.49	0	0	10.6	0.1	1
2025	11	26	0	48	1	0	0	0	0	0	0	0	6.47	0	0	10.6	0.1	1
2025	11	26	0	58	1	0	0	0	0	0	0	0	6.46	0	0	10.6	0.1	1
2025	11	26	1	8	1	0	0	0	0	0	0	0	6.44	0	0	10.6	0.1	1
2025	11	26	1	18	1	0	0	0	0	0	0	0	6.43	0	0	10.6	0.1	1
2025	11	26	1	28	1	0	0	0	0	0	0	0	6.42	0	0	10.6	0.1	1
2025	11	26	1	38	1	0	0	0	0	0	0	0	6.41	0	0	10.6	0.1	1
2025	11	26	1	48	1	0	0	0	0	0	0	0	6.4	0	0	10.6	0.1	1
2025	11	26	1	58	1	0	0	0	0	0	0	0	6.38	0	0	10.6	0.1	1
2025	11	26	2	8	1	0	0	0	0	0	0	0	6.38	0	0	10.6	0.1	1
2025	11	26	2	18	1	0	0	0	0	0	0	0	6.37	0	0	10.6	0.1	1
2025	11	26	2	28	1	0	0	0	0	0	0	0	6.37	0	0	10.8	0.1	1
2025	11	26	2	38	1	0	0	0	0	0	0	0	6.36	0	0	11	0.1	1
2025	11	26	2	48	1	0	0	0	0	0	0	0	6.35	0	0	11	0.1	1
2025	11	26	2	58	1	0	0	0	0	0	0	0	6.35	0	0	11	0.1	1
2025	11	26	3	8	1	0	0	0	0	0	0	0	6.35	0	0	11	0.1	1
2025	11	26	3	18	1	0	0	0	0	0	0	0	6.35	0	0	11	0.1	1
2025	11	26	3	28	1	0	0	0	0	0	0	0	6.35	0	0	11	0.1	1
2025	11	26	3	38	1	0	0	0	0	0	0	0	6.34	0	0	11	0.1	1
2025	11	26	3	48	1	0	0	0	0	0	0	0	6.34	0	0	11	0.1	1
2025	11	26	3	58	1	0	0	0	0	0	0	0	6.34	0	0	11	0.1	1
2025	11	26	4	8	1	0	0	0	0	0	0	0	6.34	0	0	11	0.1	1
2025	11	26	4	18	1	0	0	0	0	0	0	0	6.34	0	0	11	0.1	1
2025	11	26	4	28	1	0	0	0	0	0	0	0	6.34	0	0	11	0.1	1
2025	11	26	4	38	1	0	0	0	0	0	0	0	6.34	0	0	11	0.1	1
2025	11	26	4	48	1	0	0	0	0	0	0	0	6.34	0	0	11	0.1	1
2025	11	26	4	58	1	0	0	0	0	0	0	0	6.33	0	0	11	0.1	1
2025	11	26	5	8	1	0	0	0	0	0	0	0	6.33	0	0	11	0.1	1
2025	11	26	5	18	1	0	0	0	0	0	0	0	6.33	0	0	11	0.1	1
2025	11	26	5	28	1	0	0	0	0	0	0	0	6.33	0	0	11	0.1	1
2025	11	26	5	38	1	0	0	0	0	0	0	0	6.33	0	0	11	0.1	1
2025	11	26	5	48	1	0	0	0	0	0	0	0	6.33	0	0	11	0.1	1
2025	11	26	5	58	1	0	0	0	0	0	0	0	6.33	0	0	11	0.1	1
2025	11	26	6	8	1	0	0	0	0	0	0	0	6.33	0	0	11	0.1	1
2025	11	26	6	18	1	0	0	0	0	0	0	0	6.33	0	0	11	0.1	1
2025	11	26	6	28	1	0	0	0	0	0	0	0	6.32	0	0	11	0.1	1
2025	11	26	6	38	1	0	0	0	0	0	0	0	6.32	0	0	11	0.1	1
2025	11	26	6	48	1	0	0	0	0	0	0	0	6.32	0	0	11	0.1	1
2025	11	26	6	58	1	0	0	0	0	0	0	0	6.32	0	0	11	0.1	1
2025	11	26	7	8	1	0	0	0	0	0	0	0	6.32	0	0	11	0.1	1
2025	11	26	7	18	1	0	0	0	0	0	0	0	6.32	0	0	11	0.1	1
2025	11	26	7	28	1	0	0	0	0	0	0	0	6.33	0	0	11	0.1	1
2025	11	26	7	38	1	0	0	0	0	0	0	0	6.32	0	0	11	0.1	1
2025	11	26	7	48	1	0	0	0	0	0	0	0	6.33	0	0	11	0.1	1
2025	11	26	7	58	1	0	0	0	0	0	0	0	6.33	0	0	11	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	26	8	8	1	0	0	0	0	0	0	0	6.33	0	0	11	0.1	1
2025	11	26	8	18	1	0	0	0	0	0	0	0	6.33	0	0	11.2	0.1	1
2025	11	26	8	28	1	0	0	0	0	0	0	0	6.34	0	0	11.4	0.1	1
2025	11	26	8	38	1	0	0	0	0	0	0	0	6.34	0	0	11.6	0.1	1
2025	11	26	8	48	1	0	0	0	0	0	0	0	6.35	0	0	11.6	0.1	1
2025	11	26	8	58	1	0	0	0	0	0	0	0	6.36	0	0	11.6	0.1	1
2025	11	26	9	8	1	0	0	0	0	0	0	0	6.37	0	0	11.8	0.1	1
2025	11	26	9	18	1	0	0	0	0	0	0	0	6.39	0	0	11.8	0.1	1
2025	11	26	9	28	1	0	0	0	0	0	0	0	6.41	0	0	11.4	0.1	1
2025	11	26	9	38	1	0	0	0	0	0	0	0	6.44	0	0	11.4	0.1	1
2025	11	26	9	48	1	0	0	0	0	0	0	0	6.46	0	0	11.4	0.1	1
2025	11	26	9	58	1	0	0	0	0	0	0	0	6.48	0	0	11.4	0.1	1
2025	11	26	10	8	1	0	0	0	0	0	0	0	6.51	0	0	11.6	0.1	1
2025	11	26	10	18	1	0	0	0	0	0	0	0	6.54	0	0	11.4	0.1	1
2025	11	26	10	28	1	0	0	0	0	0	0	0	6.57	0	0	11.6	0.1	1
2025	11	26	10	38	1	0	0	0	0	0	0	0	6.6	0	0	11.6	0.1	1
2025	11	26	10	48	1	0	0	0	0	0	0	0	6.63	0	0	11.6	0.1	1
2025	11	26	10	58	1	0	0	0	0	0	0	0	6.65	0	0	11.6	0.1	1
2025	11	26	11	8	1	0	0	0	0	0	0	0	6.68	0	0	11.6	0.1	1
2025	11	26	11	18	1	0	0	0	0	0	0	0	6.71	0	0	11.6	0.1	1
2025	11	26	11	28	1	0	0	0	0	0	0	0	6.73	0	0	11.6	0.1	1
2025	11	26	11	38	1	0	0	0	0	0	0	0	6.76	0	0	11.6	0.1	1
2025	11	26	11	48	1	0	0	0	0	0	0	0	6.78	0	0	11.6	0.1	1
2025	11	26	11	58	1	0	0	0	0	0	0	0	6.81	0	0	11.6	0.1	1
2025	11	26	12	8	1	0	0	0	0	0	0	0	6.84	0	0	11.6	0.1	1
2025	11	26	12	18	1	0	0	0	0	0	0	0	6.86	0	0	11.6	0.1	1
2025	11	26	12	28	1	0	0	0	0	0	0	0	6.88	0	0	11.6	0.1	1
2025	11	26	12	38	1	0	0	0	0	0	0	0	6.9	0	0	11.6	0.1	1
2025	11	26	12	48	1	0	0	0	0	0	0	0	6.92	0	0	11.6	0.1	1
2025	11	26	12	58	1	0	0	0	0	0	0	0	6.94	0	0	11.6	0.1	1
2025	11	26	13	8	1	0	0	0	0	0	0	0	6.96	0	0	11.6	0.1	1
2025	11	26	13	18	1	0	0	0	0	0	0	0	6.98	0	0	11.6	0.1	1
2025	11	26	13	28	1	0	0	0	0	0	0	0	7	0	0	11.4	0.1	1
2025	11	26	13	38	1	0	0	0	0	0	0	0	7.01	0	0	11.4	0.1	1
2025	11	26	13	48	1	0	0	0	0	0	0	0	7.03	0	0	11.4	0.1	1
2025	11	26	13	58	1	0	0	0	0	0	0	0	7.04	0	0	11.4	0.1	1
2025	11	26	14	8	1	0	0	0	0	0	0	0	7.04	0	0	11.4	0.1	1
2025	11	26	14	18	1	0	0	0	0	0	0	0	7.06	0	0	11.4	0.1	1
2025	11	26	14	28	1	0	0	0	0	0	0	0	7.05	0	0	11.4	0.1	1
2025	11	26	14	38	1	0	0	0	0	0	0	0	7.06	0	0	11.4	0.1	1
2025	11	26	14	48	1	0	0	0	0	0	0	0	7.07	0	0	11.4	0.1	1
2025	11	26	14	58	1	0	0	0	0	0	0	0	7.07	0	0	11.4	0.1	1
2025	11	26	15	8	1	0	0	0	0	0	0	0	7.07	0	0	11.2	0.1	1
2025	11	26	15	18	1	0	0	0	0	0	0	0	7.06	0	0	11.2	0.1	1
2025	11	26	15	28	1	0	0	0	0	0	0	0	7.06	0	0	11.2	0.1	1
2025	11	26	15	38	1	0	0	0	0	0	0	0	7.05	0	0	11.2	0.1	1
2025	11	26	15	48	1	0	0	0	0	0	0	0	7.04	0	0	11.2	0.1	1
2025	11	26	15	58	1	0	0	0	0	0	0	0	7.03	0	0	11.2	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	26	16	8	1	0	0	0	0	0	0	0	7.02	0	0	11	0.1	1
2025	11	26	16	18	1	0	0	0	0	0	0	0	7	0	0	11	0.1	1
2025	11	26	16	28	1	0	0	0	0	0	0	0	6.99	0	0	11	0.1	1
2025	11	26	16	38	1	0	0	0	0	0	0	0	6.99	0	0	11	0.1	1
2025	11	26	16	48	1	0	0	0	0	0	0	0	6.98	0	0	10.8	0.1	1
2025	11	26	16	58	1	0	0	0	0	0	0	0	6.97	0	0	10.8	0.1	1
2025	11	26	17	8	1	0	0	0	0	0	0	0	6.96	0	0	10.8	0.1	1
2025	11	26	17	18	1	0	0	0	0	0	0	0	6.96	0	0	10.8	0.1	1
2025	11	26	17	28	1	0	0	0	0	0	0	0	6.95	0	0	10.8	0.1	1
2025	11	26	17	38	1	0	0	0	0	0	0	0	6.94	0	0	10.6	0.1	1
2025	11	26	17	48	1	0	0	0	0	0	0	0	6.93	0	0	10.6	0.1	1
2025	11	26	17	58	1	0	0	0	0	0	0	0	6.92	0	0	10.6	0.1	1
2025	11	26	18	8	1	0	0	0	0	0	0	0	6.91	0	0	10.6	0.1	1
2025	11	26	18	18	1	0	0	0	0	0	0	0	6.89	0	0	10.6	0.1	1
2025	11	26	18	28	1	0	0	0	0	0	0	0	6.88	0	0	10.6	0.1	1
2025	11	26	18	38	1	0	0	0	0	0	0	0	6.86	0	0	10.6	0.1	1
2025	11	26	18	48	1	0	0	0	0	0	0	0	6.84	0	0	10.6	0.1	1
2025	11	26	18	58	1	0	0	0	0	0	0	0	6.82	0	0	10.6	0.1	1
2025	11	26	19	8	1	0	0	0	0	0	0	0	6.81	0	0	10.6	0.1	1
2025	11	26	19	18	1	0	0	0	0	0	0	0	6.78	0	0	10.6	0.1	1
2025	11	26	19	28	1	0	0	0	0	0	0	0	6.77	0	0	10.6	0.1	1
2025	11	26	19	38	1	0	0	0	0	0	0	0	6.74	0	0	10.6	0.1	1
2025	11	26	19	48	1	0	0	0	0	0	0	0	6.72	0	0	10.6	0.1	1
2025	11	26	19	58	1	0	0	0	0	0	0	0	6.7	0	0	10.6	0.1	1
2025	11	26	20	8	1	0	0	0	0	0	0	0	6.68	0	0	10.6	0.1	1
2025	11	26	20	18	1	0	0	0	0	0	0	0	6.65	0	0	10.6	0.1	1
2025	11	26	20	28	1	0	0	0	0	0	0	0	6.63	0	0	10.6	0.1	1
2025	11	26	20	38	1	0	0	0	0	0	0	0	6.61	0	0	10.6	0.1	1
2025	11	26	20	48	1	0	0	0	0	0	0	0	6.59	0	0	10.6	0.1	1
2025	11	26	20	58	1	0	0	0	0	0	0	0	6.56	0	0	10.6	0.1	1
2025	11	26	21	8	1	0	0	0	0	0	0	0	6.54	0	0	10.6	0.1	1
2025	11	26	21	18	1	0	0	0	0	0	0	0	6.51	0	0	10.6	0.1	1
2025	11	26	21	28	1	0	0	0	0	0	0	0	6.49	0	0	10.6	0.1	1
2025	11	26	21	38	1	0	0	0	0	0	0	0	6.47	0	0	10.6	0.1	1
2025	11	26	21	48	1	0	0	0	0	0	0	0	6.45	0	0	10.6	0.1	1
2025	11	26	21	58	1	0	0	0	0	0	0	0	6.42	0	0	10.6	0.1	1
2025	11	26	22	8	1	0	0	0	0	0	0	0	6.4	0	0	10.6	0.1	1
2025	11	26	22	18	1	0	0	0	0	0	0	0	6.37	0	0	10.6	0.1	1
2025	11	26	22	28	1	0	0	0	0	0	0	0	6.35	0	0	10.6	0.1	1
2025	11	26	22	38	1	0	0	0	0	0	0	0	6.33	0	0	10.6	0.1	1
2025	11	26	22	48	1	0	0	0	0	0	0	0	6.3	0	0	10.6	0.1	1
2025	11	26	22	58	1	0	0	0	0	0	0	0	6.29	0	0	10.6	0.1	1
2025	11	26	23	8	1	0	0	0	0	0	0	0	6.26	0	0	10.6	0.1	1
2025	11	26	23	18	1	0	0	0	0	0	0	0	6.24	0	0	10.6	0.1	1
2025	11	26	23	28	1	0	0	0	0	0	0	0	6.22	0	0	10.6	0.1	1
2025	11	26	23	38	1	0	0	0	0	0	0	0	6.2	0	0	10.6	0.1	1
2025	11	26	23	48	1	0	0	0	0	0	0	0	6.19	0	0	10.6	0.1	1
2025	11	26	23	58	1	0	0	0	0	0	0	0	6.17	0	0	10.6	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	27	0	8	1	0	0	0	0	0	0	0	6.15	0	0	10.6	0.1	1
2025	11	27	0	18	1	0	0	0	0	0	0	0	6.13	0	0	10.6	0.1	1
2025	11	27	0	28	1	0	0	0	0	0	0	0	6.11	0	0	10.6	0.1	1
2025	11	27	0	38	1	0	0	0	0	0	0	0	6.1	0	0	10.6	0.1	1
2025	11	27	0	48	1	0	0	0	0	0	0	0	6.08	0	0	10.6	0.1	1
2025	11	27	0	58	1	0	0	0	0	0	0	0	6.07	0	0	10.6	0.1	1
2025	11	27	1	8	1	0	0	0	0	0	0	0	6.06	0	0	10.6	0.1	1
2025	11	27	1	18	1	0	0	0	0	0	0	0	6.05	0	0	10.6	0.1	1
2025	11	27	1	28	1	0	0	0	0	0	0	0	6.04	0	0	10.6	0.1	1
2025	11	27	1	38	1	0	0	0	0	0	0	0	6.03	0	0	10.6	0.1	1
2025	11	27	1	48	1	0	0	0	0	0	0	0	6.02	0	0	10.6	0.1	1
2025	11	27	1	58	1	0	0	0	0	0	0	0	6.02	0	0	10.6	0.1	1
2025	11	27	2	8	1	0	0	0	0	0	0	0	6.02	0	0	10.6	0.1	1
2025	11	27	2	18	1	0	0	0	0	0	0	0	6.01	0	0	10.6	0.1	1
2025	11	27	2	28	1	0	0	0	0	0	0	0	6.01	0	0	10.6	0.1	1
2025	11	27	2	38	1	0	0	0	0	0	0	0	6	0	0	10.6	0.1	1
2025	11	27	2	48	1	0	0	0	0	0	0	0	6	0	0	10.6	0.1	1
2025	11	27	2	58	1	0	0	0	0	0	0	0	6	0	0	10.6	0.1	1
2025	11	27	3	8	1	0	0	0	0	0	0	0	6	0	0	10.4	0.1	1
2025	11	27	3	18	1	0	0	0	0	0	0	0	6	0	0	10.4	0.1	1
2025	11	27	3	28	1	0	0	0	0	0	0	0	6	0	0	10.4	0.1	1
2025	11	27	3	38	1	0	0	0	0	0	0	0	5.99	0	0	10.6	0.1	1
2025	11	27	3	48	1	0	0	0	0	0	0	0	5.99	0	0	11.2	0.1	1
2025	11	27	3	58	1	0	0	0	0	0	0	0	5.99	0	0	11	0.1	1
2025	11	27	4	8	1	0	0	0	0	0	0	0	5.98	0	0	11	0.1	1
2025	11	27	4	18	1	0	0	0	0	0	0	0	5.98	0	0	11	0.1	1
2025	11	27	4	28	1	0	0	0	0	0	0	0	5.98	0	0	11	0.1	1
2025	11	27	4	38	1	0	0	0	0	0	0	0	5.98	0	0	11	0.1	1
2025	11	27	4	48	1	0	0	0	0	0	0	0	5.98	0	0	11	0.1	1
2025	11	27	4	58	1	0	0	0	0	0	0	0	5.97	0	0	11	0.1	1
2025	11	27	5	8	1	0	0	0	0	0	0	0	5.97	0	0	11	0.1	1
2025	11	27	5	18	1	0	0	0	0	0	0	0	5.97	0	0	11	0.1	1
2025	11	27	5	28	1	0	0	0	0	0	0	0	5.97	0	0	11	0.1	1
2025	11	27	5	38	1	0	0	0	0	0	0	0	5.96	0	0	11	0.1	1
2025	11	27	5	48	1	0	0	0	0	0	0	0	5.96	0	0	11	0.1	1
2025	11	27	5	58	1	0	0	0	0	0	0	0	5.96	0	0	11	0.1	1
2025	11	27	6	8	1	0	0	0	0	0	0	0	5.96	0	0	11	0.1	1
2025	11	27	6	18	1	0	0	0	0	0	0	0	5.95	0	0	11	0.1	1
2025	11	27	6	28	1	0	0	0	0	0	0	0	5.95	0	0	11	0.1	1
2025	11	27	6	38	1	0	0	0	0	0	0	0	5.95	0	0	11	0.1	1
2025	11	27	6	48	1	0	0	0	0	0	0	0	5.96	0	0	11	0.1	1
2025	11	27	6	58	1	0	0	0	0	0	0	0	5.96	0	0	11	0.1	1
2025	11	27	7	8	1	0	0	0	0	0	0	0	5.96	0	0	11	0.1	1
2025	11	27	7	18	1	0	0	0	0	0	0	0	5.96	0	0	11	0.1	1
2025	11	27	7	28	1	0	0	0	0	0	0	0	5.96	0	0	11	0.1	1
2025	11	27	7	38	1	0	0	0	0	0	0	0	5.96	0	0	11	0.1	1
2025	11	27	7	48	1	0	0	0	0	0	0	0	5.96	0	0	11	0.1	1
2025	11	27	7	58	1	0	0	0	0	0	0	0	5.97	0	0	11	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	27	8	8	1	0	0	0	0	0	0	0	5.97	0	0	11	0.1	1
2025	11	27	8	18	1	0	0	0	0	0	0	0	5.98	0	0	11.2	0.1	1
2025	11	27	8	28	1	0	0	0	0	0	0	0	5.99	0	0	11.2	0.1	1
2025	11	27	8	38	1	0	0	0	0	0	0	0	6	0	0	11.4	0.1	1
2025	11	27	8	48	1	0	0	0	0	0	0	0	6.01	0	0	11.2	0.1	1
2025	11	27	8	58	1	0	0	0	0	0	0	0	6.03	0	0	11.6	0.1	1
2025	11	27	9	8	1	0	0	0	0	0	0	0	6.04	0	0	11.8	0.1	1
2025	11	27	9	18	1	0	0	0	0	0	0	0	6.06	0	0	12	0.1	1
2025	11	27	9	28	1	0	0	0	0	0	0	0	6.09	0	0	11.8	0.1	1
2025	11	27	9	38	1	0	0	0	0	0	0	0	6.12	0	0	12	0.1	1
2025	11	27	9	48	1	0	0	0	0	0	0	0	6.14	0	0	11.4	0.1	1
2025	11	27	9	58	1	0	0	0	0	0	0	0	6.16	0	0	11.2	0.1	1
2025	11	27	10	8	1	0	0	0	0	0	0	0	6.18	0	0	11.2	0.1	1
2025	11	27	10	18	1	0	0	0	0	0	0	0	6.2	0	0	11.2	0.1	1
2025	11	27	10	28	1	0	0	0	0	0	0	0	6.23	0	0	11.2	0.1	1
2025	11	27	10	38	1	0	0	0	0	0	0	0	6.26	0	0	11.4	0.1	1
2025	11	27	10	48	1	0	0	0	0	0	0	0	6.27	0	0	11	0.1	1
2025	11	27	10	58	1	0	0	0	0	0	0	0	6.29	0	0	11	0.1	1
2025	11	27	11	8	1	0	0	0	0	0	0	0	6.3	0	0	11.2	0.1	1
2025	11	27	11	18	1	0	0	0	0	0	0	0	6.33	0	0	11.2	0.1	1
2025	11	27	11	28	1	0	0	0	0	0	0	0	6.35	0	0	11.2	0.1	1
2025	11	27	11	38	1	0	0	0	0	0	0	0	6.37	0	0	11.2	0.1	1
2025	11	27	11	48	1	0	0	0	0	0	0	0	6.39	0	0	11.2	0.1	1
2025	11	27	11	58	1	0	0	0	0	0	0	0	6.41	0	0	11.4	0.1	1
2025	11	27	12	8	1	0	0	0	0	0	0	0	6.44	0	0	11.4	0.1	1
2025	11	27	12	18	1	0	0	0	0	0	0	0	6.47	0	0	11.4	0.1	1
2025	11	27	12	28	1	0	0	0	0	0	0	0	6.49	0	0	11.4	0.1	1
2025	11	27	12	38	1	0	0	0	0	0	0	0	6.51	0	0	11.4	0.1	1
2025	11	27	12	48	1	0	0	0	0	0	0	0	6.54	0	0	11.4	0.1	1
2025	11	27	12	58	1	0	0	0	0	0	0	0	6.57	0	0	11.4	0.1	1
2025	11	27	13	8	1	0	0	0	0	0	0	0	6.58	0	0	11.4	0.1	1
2025	11	27	13	18	1	0	0	0	0	0	0	0	6.6	0	0	11.4	0.1	1
2025	11	27	13	28	1	0	0	0	0	0	0	0	6.62	0	0	11.4	0.1	1
2025	11	27	13	38	1	0	0	0	0	0	0	0	6.65	0	0	11.4	0.1	1
2025	11	27	13	48	1	0	0	0	0	0	0	0	6.66	0	0	11.2	0.1	1
2025	11	27	13	58	1	0	0	0	0	0	0	0	6.66	0	0	11	0.1	1
2025	11	27	14	8	1	0	0	0	0	0	0	0	6.65	0	0	11	0.1	1
2025	11	27	14	18	1	0	0	0	0	0	0	0	6.65	0	0	10.8	0.1	1
2025	11	27	14	28	1	0	0	0	0	0	0	0	6.64	0	0	11	0.1	1
2025	11	27	14	38	1	0	0	0	0	0	0	0	6.65	0	0	11	0.1	1
2025	11	27	14	48	1	0	0	0	0	0	0	0	6.65	0	0	11	0.1	1
2025	11	27	14	58	1	0	0	0	0	0	0	0	6.66	0	0	11	0.1	1
2025	11	27	15	8	1	0	0	0	0	0	0	0	6.67	0	0	11	0.1	1
2025	11	27	15	18	1	0	0	0	0	0	0	0	6.67	0	0	11	0.1	1
2025	11	27	15	28	1	0	0	0	0	0	0	0	6.68	0	0	11	0.1	1
2025	11	27	15	38	1	0	0	0	0	0	0	0	6.68	0	0	10.8	0.1	1
2025	11	27	15	48	1	0	0	0	0	0	0	0	6.68	0	0	10.8	0.1	1
2025	11	27	15	58	1	0	0	0	0	0	0	0	6.67	0	0	10.8	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	27	16	8	1	0	0	0	0	0	0	0	6.66	0	0	10.8	0.1	1
2025	11	27	16	18	1	0	0	0	0	0	0	0	6.65	0	0	10.6	0.1	1
2025	11	27	16	28	1	0	0	0	0	0	0	0	6.64	0	0	10.6	0.1	1
2025	11	27	16	38	1	0	0	0	0	0	0	0	6.64	0	0	10.6	0.1	1
2025	11	27	16	48	1	0	0	0	0	0	0	0	6.63	0	0	10.4	0.1	1
2025	11	27	16	58	1	0	0	0	0	0	0	0	6.62	0	0	10.8	0.1	1
2025	11	27	17	8	1	0	0	0	0	0	0	0	6.62	0	0	10.6	0.1	1
2025	11	27	17	18	1	0	0	0	0	0	0	0	6.6	0	0	10.4	0.1	1
2025	11	27	17	28	1	0	0	0	0	0	0	0	6.6	0	0	10.4	0.1	1
2025	11	27	17	38	1	0	0	0	0	0	0	0	6.58	0	0	10.4	0.1	1
2025	11	27	17	48	1	0	0	0	0	0	0	0	6.57	0	0	10.4	0.1	1
2025	11	27	17	58	1	0	0	0	0	0	0	0	6.55	0	0	10.4	0.1	1
2025	11	27	18	8	1	0	0	0	0	0	0	0	6.55	0	0	10.4	0.1	1
2025	11	27	18	18	1	0	0	0	0	0	0	0	6.53	0	0	10.4	0.1	1
2025	11	27	18	28	1	0	0	0	0	0	0	0	6.52	0	0	10.4	0.1	1
2025	11	27	18	38	1	0	0	0	0	0	0	0	6.5	0	0	10.4	0.1	1
2025	11	27	18	48	1	0	0	0	0	0	0	0	6.48	0	0	10.4	0.1	1
2025	11	27	18	58	1	0	0	0	0	0	0	0	6.46	0	0	10.4	0.1	1
2025	11	27	19	8	1	0	0	0	0	0	0	0	6.44	0	0	10.4	0.1	1
2025	11	27	19	18	1	0	0	0	0	0	0	0	6.42	0	0	11.2	0.1	1
2025	11	27	19	28	1	0	0	0	0	0	0	0	6.4	0	0	11.4	0.1	1
2025	11	27	19	38	1	0	0	0	0	0	0	0	6.38	0	0	11.4	0.1	1
2025	11	27	19	48	1	0	0	0	0	0	0	0	6.36	0	0	11.4	0.1	1
2025	11	27	19	58	1	0	0	0	0	0	0	0	6.34	0	0	11.4	0.1	1
2025	11	27	20	8	1	0	0	0	0	0	0	0	6.31	0	0	11.4	0.1	1
2025	11	27	20	18	1	0	0	0	0	0	0	0	6.29	0	0	11.4	0.1	1
2025	11	27	20	28	1	0	0	0	0	0	0	0	6.27	0	0	11.4	0.1	1
2025	11	27	20	38	1	0	0	0	0	0	0	0	6.25	0	0	11.2	0.1	1
2025	11	27	20	48	1	0	0	0	0	0	0	0	6.23	0	0	11.2	0.1	1
2025	11	27	20	58	1	0	0	0	0	0	0	0	6.2	0	0	11.2	0.1	1
2025	11	27	21	8	1	0	0	0	0	0	0	0	6.19	0	0	11.2	0.1	1
2025	11	27	21	18	1	0	0	0	0	0	0	0	6.16	0	0	11.2	0.1	1
2025	11	27	21	28	1	0	0	0	0	0	0	0	6.15	0	0	11.2	0.1	1
2025	11	27	21	38	1	0	0	0	0	0	0	0	6.13	0	0	11.2	0.1	1
2025	11	27	21	48	1	0	0	0	0	0	0	0	6.1	0	0	11.2	0.1	1
2025	11	27	21	58	1	0	0	0	0	0	0	0	6.08	0	0	11.2	0.1	1
2025	11	27	22	8	1	0	0	0	0	0	0	0	6.07	0	0	11.2	0.1	1
2025	11	27	22	18	1	0	0	0	0	0	0	0	6.04	0	0	11.2	0.1	1
2025	11	27	22	28	1	0	0	0	0	0	0	0	6.02	0	0	11.2	0.1	1
2025	11	27	22	38	1	0	0	0	0	0	0	0	6	0	0	11.2	0.1	1
2025	11	27	22	48	1	0	0	0	0	0	0	0	5.98	0	0	11.2	0.1	1
2025	11	27	22	58	1	0	0	0	0	0	0	0	5.97	0	0	11.2	0.1	1
2025	11	27	23	8	1	0	0	0	0	0	0	0	5.95	0	0	11.2	0.1	1
2025	11	27	23	18	1	0	0	0	0	0	0	0	5.93	0	0	11.2	0.1	1
2025	11	27	23	28	1	0	0	0	0	0	0	0	5.91	0	0	11.2	0.1	1
2025	11	27	23	38	1	0	0	0	0	0	0	0	5.89	0	0	11.2	0.1	1
2025	11	27	23	48	1	0	0	0	0	0	0	0	5.87	0	0	11	0.1	1
2025	11	27	23	58	1	0	0	0	0	0	0	0	5.85	0	0	11	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	28	0	8	1	0	0	0	0	0	0	0	5.84	0	0	11	0.1	1
2025	11	28	0	18	1	0	0	0	0	0	0	0	5.82	0	0	11	0.1	1
2025	11	28	0	28	1	0	0	0	0	0	0	0	5.81	0	0	11	0.1	1
2025	11	28	0	38	1	0	0	0	0	0	0	0	5.8	0	0	11	0.1	1
2025	11	28	0	48	1	0	0	0	0	0	0	0	5.79	0	0	11	0.1	1
2025	11	28	0	58	1	0	0	0	0	0	0	0	5.77	0	0	11	0.1	1
2025	11	28	1	8	1	0	0	0	0	0	0	0	5.75	0	0	11	0.1	1
2025	11	28	1	18	1	0	0	0	0	0	0	0	5.75	0	0	11	0.1	1
2025	11	28	1	28	1	0	0	0	0	0	0	0	5.74	0	0	11	0.1	1
2025	11	28	1	38	1	0	0	0	0	0	0	0	5.73	0	0	11	0.1	1
2025	11	28	1	48	1	0	0	0	0	0	0	0	5.73	0	0	11	0.1	1
2025	11	28	1	58	1	0	0	0	0	0	0	0	5.72	0	0	11	0.1	1
2025	11	28	2	8	1	0	0	0	0	0	0	0	5.71	0	0	11	0.1	1
2025	11	28	2	18	1	0	0	0	0	0	0	0	5.71	0	0	11	0.1	1
2025	11	28	2	28	1	0	0	0	0	0	0	0	5.7	0	0	11	0.1	1
2025	11	28	2	38	1	0	0	0	0	0	0	0	5.69	0	0	11	0.1	1
2025	11	28	2	48	1	0	0	0	0	0	0	0	5.69	0	0	11	0.1	1
2025	11	28	2	58	1	0	0	0	0	0	0	0	5.69	0	0	11	0.1	1
2025	11	28	3	8	1	0	0	0	0	0	0	0	5.69	0	0	11	0.1	1
2025	11	28	3	18	1	0	0	0	0	0	0	0	5.69	0	0	11	0.1	1
2025	11	28	3	28	1	0	0	0	0	0	0	0	5.69	0	0	11	0.1	1
2025	11	28	3	38	1	0	0	0	0	0	0	0	5.69	0	0	11	0.1	1
2025	11	28	3	48	1	0	0	0	0	0	0	0	5.68	0	0	11	0.1	1
2025	11	28	3	58	1	0	0	0	0	0	0	0	5.68	0	0	11	0.1	1
2025	11	28	4	8	1	0	0	0	0	0	0	0	5.68	0	0	11	0.1	1
2025	11	28	4	18	1	0	0	0	0	0	0	0	5.68	0	0	11	0.1	1
2025	11	28	4	28	1	0	0	0	0	0	0	0	5.68	0	0	11	0.1	1
2025	11	28	4	38	1	0	0	0	0	0	0	0	5.68	0	0	11	0.1	1
2025	11	28	4	48	1	0	0	0	0	0	0	0	5.68	0	0	11	0.1	1
2025	11	28	4	58	1	0	0	0	0	0	0	0	5.68	0	0	11	0.1	1
2025	11	28	5	8	1	0	0	0	0	0	0	0	5.68	0	0	11	0.1	1
2025	11	28	5	18	1	0	0	0	0	0	0	0	5.68	0	0	11	0.1	1
2025	11	28	5	28	1	0	0	0	0	0	0	0	5.68	0	0	11	0.1	1
2025	11	28	5	38	1	0	0	0	0	0	0	0	5.69	0	0	11	0.1	1
2025	11	28	5	48	1	0	0	0	0	0	0	0	5.69	0	0	11	0.1	1
2025	11	28	5	58	1	0	0	0	0	0	0	0	5.69	0	0	11	0.1	1
2025	11	28	6	8	1	0	0	0	0	0	0	0	5.68	0	0	11	0.1	1
2025	11	28	6	18	1	0	0	0	0	0	0	0	5.69	0	0	11	0.1	1
2025	11	28	6	28	1	0	0	0	0	0	0	0	5.69	0	0	11	0.1	1
2025	11	28	6	38	1	0	0	0	0	0	0	0	5.69	0	0	11	0.1	1
2025	11	28	6	48	1	0	0	0	0	0	0	0	5.69	0	0	11	0.1	1
2025	11	28	6	58	1	0	0	0	0	0	0	0	5.69	0	0	11	0.1	1
2025	11	28	7	8	1	0	0	0	0	0	0	0	5.7	0	0	11	0.1	1
2025	11	28	7	18	1	0	0	0	0	0	0	0	5.69	0	0	11	0.1	1
2025	11	28	7	28	1	0	0	0	0	0	0	0	5.7	0	0	11	0.1	1
2025	11	28	7	38	1	0	0	0	0	0	0	0	5.69	0	0	11	0.1	1
2025	11	28	7	48	1	0	0	0	0	0	0	0	5.7	0	0	11	0.1	1
2025	11	28	7	58	1	0	0	0	0	0	0	0	5.7	0	0	11	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	28	8	8	1	0	0	0	0	0	0	0	5.7	0	0	11	0.1	1
2025	11	28	8	18	1	0	0	0	0	0	0	0	5.7	0	0	11.2	0.1	1
2025	11	28	8	28	1	0	0	0	0	0	0	0	5.71	0	0	11.4	0.1	1
2025	11	28	8	38	1	0	0	0	0	0	0	0	5.71	0	0	11.6	0.1	1
2025	11	28	8	48	1	0	0	0	0	0	0	0	5.71	0	0	11.6	0.1	1
2025	11	28	8	58	1	0	0	0	0	0	0	0	5.72	0	0	11.8	0.1	1
2025	11	28	9	8	1	0	0	0	0	0	0	0	5.73	0	0	11.8	0.1	1
2025	11	28	9	18	1	0	0	0	0	0	0	0	5.74	0	0	12	0.1	1
2025	11	28	9	28	1	0	0	0	0	0	0	0	5.76	0	0	12	0.1	1
2025	11	28	9	38	1	0	0	0	0	0	0	0	5.78	0	0	12	0.1	1
2025	11	28	9	48	1	0	0	0	0	0	0	0	5.81	0	0	11.4	0.1	1
2025	11	28	9	58	1	0	0	0	0	0	0	0	5.83	0	0	11.4	0.1	1
2025	11	28	10	8	1	0	0	0	0	0	0	0	5.86	0	0	11.4	0.1	1
2025	11	28	10	18	1	0	0	0	0	0	0	0	5.89	0	0	11.4	0.1	1
2025	11	28	10	28	1	0	0	0	0	0	0	0	5.92	0	0	11.4	0.1	1
2025	11	28	10	38	1	0	0	0	0	0	0	0	5.94	0	0	11.4	0.1	1
2025	11	28	10	48	1	0	0	0	0	0	0	0	5.96	0	0	11.4	0.1	1
2025	11	28	10	58	1	0	0	0	0	0	0	0	5.99	0	0	11.4	0.1	1
2025	11	28	11	8	1	0	0	0	0	0	0	0	6.02	0	0	11.4	0.1	1
2025	11	28	11	18	1	0	0	0	0	0	0	0	6.05	0	0	11.4	0.1	1
2025	11	28	11	28	1	0	0	0	0	0	0	0	6.07	0	0	11.4	0.1	1
2025	11	28	11	38	1	0	0	0	0	0	0	0	6.09	0	0	11.4	0.1	1
2025	11	28	11	48	1	0	0	0	0	0	0	0	6.12	0	0	11.4	0.1	1
2025	11	28	11	58	1	0	0	0	0	0	0	0	6.14	0	0	11.4	0.1	1
2025	11	28	12	8	1	0	0	0	0	0	0	0	6.16	0	0	11.4	0.1	1
2025	11	28	12	18	1	0	0	0	0	0	0	0	6.19	0	0	11.4	0.1	1
2025	11	28	12	28	1	0	0	0	0	0	0	0	6.21	0	0	11.4	0.1	1
2025	11	28	12	38	1	0	0	0	0	0	0	0	6.23	0	0	11.4	0.1	1
2025	11	28	12	48	1	0	0	0	0	0	0	0	6.26	0	0	11.4	0.1	1
2025	11	28	12	58	1	0	0	0	0	0	0	0	6.27	0	0	11.6	0.1	1
2025	11	28	13	8	1	0	0	0	0	0	0	0	6.29	0	0	11.8	0.1	1
2025	11	28	13	18	1	0	0	0	0	0	0	0	6.31	0	0	12.2	0.1	1
2025	11	28	13	28	1	0	0	0	0	0	0	0	6.33	0	0	12	0.1	1
2025	11	28	13	38	1	0	0	0	0	0	0	0	6.35	0	0	12.8	0.1	1
2025	11	28	13	48	1	0	0	0	0	0	0	0	6.36	0	0	12	0.1	1
2025	11	28	13	58	1	0	0	0	0	0	0	0	6.38	0	0	12	0.1	1
2025	11	28	14	8	1	0	0	0	0	0	0	0	6.39	0	0	11.6	0.1	1
2025	11	28	14	18	1	0	0	0	0	0	0	0	6.39	0	0	11.4	0.1	1
2025	11	28	14	28	1	0	0	0	0	0	0	0	6.4	0	0	11.2	0.1	1
2025	11	28	14	38	1	0	0	0	0	0	0	0	6.4	0	0	11.2	0.1	1
2025	11	28	14	48	1	0	0	0	0	0	0	0	6.4	0	0	11.2	0.1	1
2025	11	28	14	58	1	0	0	0	0	0	0	0	6.41	0	0	11.2	0.1	1
2025	11	28	15	8	1	0	0	0	0	0	0	0	6.41	0	0	11.2	0.1	1
2025	11	28	15	18	1	0	0	0	0	0	0	0	6.41	0	0	11.2	0.1	1
2025	11	28	15	28	1	0	0	0	0	0	0	0	6.41	0	0	11	0.1	1
2025	11	28	15	38	1	0	0	0	0	0	0	0	6.4	0	0	11	0.1	1
2025	11	28	15	48	1	0	0	0	0	0	0	0	6.4	0	0	11	0.1	1
2025	11	28	15	58	1	0	0	0	0	0	0	0	6.4	0	0	11	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	28	16	8	1	0	0	0	0	0	0	0	6.39	0	0	11	0.1	1
2025	11	28	16	18	1	0	0	0	0	0	0	0	6.39	0	0	10.8	0.1	1
2025	11	28	16	28	1	0	0	0	0	0	0	0	6.38	0	0	10.8	0.1	1
2025	11	28	16	38	1	0	0	0	0	0	0	0	6.37	0	0	10.8	0.1	1
2025	11	28	16	48	1	0	0	0	0	0	0	0	6.37	0	0	10.6	0.1	1
2025	11	28	16	58	1	0	0	0	0	0	0	0	6.37	0	0	10.6	0.1	1
2025	11	28	17	8	1	0	0	0	0	0	0	0	6.37	0	0	10.6	0.1	1
2025	11	28	17	18	1	0	0	0	0	0	0	0	6.36	0	0	10.6	0.1	1
2025	11	28	17	28	1	0	0	0	0	0	0	0	6.36	0	0	10.6	0.1	1
2025	11	28	17	38	1	0	0	0	0	0	0	0	6.35	0	0	10.4	0.1	1
2025	11	28	17	48	1	0	0	0	0	0	0	0	6.34	0	0	10.4	0.1	1
2025	11	28	17	58	1	0	0	0	0	0	0	0	6.34	0	0	10.4	0.1	1
2025	11	28	18	8	1	0	0	0	0	0	0	0	6.33	0	0	10.4	0.1	1
2025	11	28	18	18	1	0	0	0	0	0	0	0	6.32	0	0	10.4	0.1	1
2025	11	28	18	28	1	0	0	0	0	0	0	0	6.31	0	0	10.4	0.1	1
2025	11	28	18	38	1	0	0	0	0	0	0	0	6.29	0	0	10.6	0.1	1
2025	11	28	18	48	1	0	0	0	0	0	0	0	6.28	0	0	10.6	0.1	1
2025	11	28	18	58	1	0	0	0	0	0	0	0	6.27	0	0	10.4	0.1	1
2025	11	28	19	8	1	0	0	0	0	0	0	0	6.25	0	0	10.4	0.1	1
2025	11	28	19	18	1	0	0	0	0	0	0	0	6.23	0	0	10.4	0.1	1
2025	11	28	19	28	1	0	0	0	0	0	0	0	6.21	0	0	10.6	0.1	1
2025	11	28	19	38	1	0	0	0	0	0	0	0	6.19	0	0	11.4	0.1	1
2025	11	28	19	48	1	0	0	0	0	0	0	0	6.17	0	0	11.4	0.1	1
2025	11	28	19	58	1	0	0	0	0	0	0	0	6.15	0	0	11.4	0.1	1
2025	11	28	20	8	1	0	0	0	0	0	0	0	6.14	0	0	11.2	0.1	1
2025	11	28	20	18	1	0	0	0	0	0	0	0	6.11	0	0	11.2	0.1	1
2025	11	28	20	28	1	0	0	0	0	0	0	0	6.09	0	0	11.2	0.1	1
2025	11	28	20	38	1	0	0	0	0	0	0	0	6.07	0	0	11.2	0.1	1
2025	11	28	20	48	1	0	0	0	0	0	0	0	6.05	0	0	11.2	0.1	1
2025	11	28	20	58	1	0	0	0	0	0	0	0	6.03	0	0	11.2	0.1	1
2025	11	28	21	8	1	0	0	0	0	0	0	0	6.01	0	0	11.2	0.1	1
2025	11	28	21	18	1	0	0	0	0	0	0	0	5.99	0	0	11.2	0.1	1
2025	11	28	21	28	1	0	0	0	0	0	0	0	5.97	0	0	11.2	0.1	1
2025	11	28	21	38	1	0	0	0	0	0	0	0	5.95	0	0	11.2	0.1	1
2025	11	28	21	48	1	0	0	0	0	0	0	0	5.93	0	0	11.2	0.1	1
2025	11	28	21	58	1	0	0	0	0	0	0	0	5.91	0	0	11.2	0.1	1
2025	11	28	22	8	1	0	0	0	0	0	0	0	5.89	0	0	11.2	0.1	1
2025	11	28	22	18	1	0	0	0	0	0	0	0	5.86	0	0	11.2	0.1	1
2025	11	28	22	28	1	0	0	0	0	0	0	0	5.84	0	0	11.2	0.1	1
2025	11	28	22	38	1	0	0	0	0	0	0	0	5.82	0	0	11.2	0.1	1
2025	11	28	22	48	1	0	0	0	0	0	0	0	5.8	0	0	11.2	0.1	1
2025	11	28	22	58	1	0	0	0	0	0	0	0	5.78	0	0	11.2	0.1	1
2025	11	28	23	8	1	0	0	0	0	0	0	0	5.76	0	0	11.2	0.1	1
2025	11	28	23	18	1	0	0	0	0	0	0	0	5.75	0	0	11.2	0.1	1
2025	11	28	23	28	1	0	0	0	0	0	0	0	5.73	0	0	11.2	0.1	1
2025	11	28	23	38	1	0	0	0	0	0	0	0	5.71	0	0	11.2	0.1	1
2025	11	28	23	48	1	0	0	0	0	0	0	0	5.7	0	0	11.2	0.1	1
2025	11	28	23	58	1	0	0	0	0	0	0	0	5.68	0	0	11.2	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	29	0	8	1	0	0	0	0	0	0	0	5.66	0	0	11.2	0.1	1
2025	11	29	0	18	1	0	0	0	0	0	0	0	5.64	0	0	11.2	0.1	1
2025	11	29	0	28	1	0	0	0	0	0	0	0	5.63	0	0	11.2	0.1	1
2025	11	29	0	38	1	0	0	0	0	0	0	0	5.62	0	0	11.2	0.1	1
2025	11	29	0	48	1	0	0	0	0	0	0	0	5.61	0	0	11.2	0.1	1
2025	11	29	0	58	1	0	0	0	0	0	0	0	5.6	0	0	11.2	0.1	1
2025	11	29	1	8	1	0	0	0	0	0	0	0	5.59	0	0	11.2	0.1	1
2025	11	29	1	18	1	0	0	0	0	0	0	0	5.59	0	0	11.2	0.1	1
2025	11	29	1	28	1	0	0	0	0	0	0	0	5.58	0	0	11.2	0.1	1
2025	11	29	1	38	1	0	0	0	0	0	0	0	5.57	0	0	11.2	0.1	1
2025	11	29	1	48	1	0	0	0	0	0	0	0	5.57	0	0	11.2	0.1	1
2025	11	29	1	58	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	2	8	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	2	18	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	2	28	1	0	0	0	0	0	0	0	5.55	0	0	11.2	0.1	1
2025	11	29	2	38	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	2	48	1	0	0	0	0	0	0	0	5.55	0	0	11.2	0.1	1
2025	11	29	2	58	1	0	0	0	0	0	0	0	5.55	0	0	11.2	0.1	1
2025	11	29	3	8	1	0	0	0	0	0	0	0	5.55	0	0	11.2	0.1	1
2025	11	29	3	18	1	0	0	0	0	0	0	0	5.55	0	0	11.2	0.1	1
2025	11	29	3	28	1	0	0	0	0	0	0	0	5.55	0	0	11.2	0.1	1
2025	11	29	3	38	1	0	0	0	0	0	0	0	5.55	0	0	11.2	0.1	1
2025	11	29	3	48	1	0	0	0	0	0	0	0	5.55	0	0	11.2	0.1	1
2025	11	29	3	58	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	4	8	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	4	18	1	0	0	0	0	0	0	0	5.55	0	0	11.2	0.1	1
2025	11	29	4	28	1	0	0	0	0	0	0	0	5.55	0	0	11.2	0.1	1
2025	11	29	4	38	1	0	0	0	0	0	0	0	5.55	0	0	11.2	0.1	1
2025	11	29	4	48	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	4	58	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	5	8	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	5	18	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	5	28	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	5	38	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	5	48	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	5	58	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	6	8	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	6	18	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	6	28	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	6	38	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	6	48	1	0	0	0	0	0	0	0	5.57	0	0	11.2	0.1	1
2025	11	29	6	58	1	0	0	0	0	0	0	0	5.57	0	0	11.2	0.1	1
2025	11	29	7	8	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	7	18	1	0	0	0	0	0	0	0	5.57	0	0	11.2	0.1	1
2025	11	29	7	28	1	0	0	0	0	0	0	0	5.57	0	0	11.2	0.1	1
2025	11	29	7	38	1	0	0	0	0	0	0	0	5.57	0	0	11.2	0.1	1
2025	11	29	7	48	1	0	0	0	0	0	0	0	5.57	0	0	11.2	0.1	1
2025	11	29	7	58	1	0	0	0	0	0	0	0	5.58	0	0	11.2	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	29	8	8	1	0	0	0	0	0	0	0	5.58	0	0	11.2	0.1	1
2025	11	29	8	18	1	0	0	0	0	0	0	0	5.58	0	0	11.4	0.1	1
2025	11	29	8	28	1	0	0	0	0	0	0	0	5.59	0	0	11.4	0.1	1
2025	11	29	8	38	1	0	0	0	0	0	0	0	5.6	0	0	11.6	0.1	1
2025	11	29	8	48	1	0	0	0	0	0	0	0	5.62	0	0	11.6	0.1	1
2025	11	29	8	58	1	0	0	0	0	0	0	0	5.63	0	0	11.8	0.1	1
2025	11	29	9	8	1	0	0	0	0	0	0	0	5.64	0	0	11.8	0.1	1
2025	11	29	9	18	1	0	0	0	0	0	0	0	5.65	0	0	11.8	0.1	1
2025	11	29	9	28	1	0	0	0	0	0	0	0	5.68	0	0	12	0.1	1
2025	11	29	9	38	1	0	0	0	0	0	0	0	5.7	0	0	12	0.1	1
2025	11	29	9	48	1	0	0	0	0	0	0	0	5.73	0	0	11.4	0.1	1
2025	11	29	9	58	1	0	0	0	0	0	0	0	5.75	0	0	11.2	0.1	1
2025	11	29	10	8	1	0	0	0	0	0	0	0	5.77	0	0	11.2	0.1	1
2025	11	29	10	18	1	0	0	0	0	0	0	0	5.8	0	0	11	0.1	1
2025	11	29	10	28	1	0	0	0	0	0	0	0	5.81	0	0	11	0.1	1
2025	11	29	10	38	1	0	0	0	0	0	0	0	5.83	0	0	11	0.1	1
2025	11	29	10	48	1	0	0	0	0	0	0	0	5.85	0	0	11	0.1	1
2025	11	29	10	58	1	0	0	0	0	0	0	0	5.87	0	0	11	0.1	1
2025	11	29	11	8	1	0	0	0	0	0	0	0	5.89	0	0	11	0.1	1
2025	11	29	11	18	1	0	0	0	0	0	0	0	5.9	0	0	10.8	0.1	1
2025	11	29	11	28	1	0	0	0	0	0	0	0	5.92	0	0	10.8	0.1	1
2025	11	29	11	38	1	0	0	0	0	0	0	0	5.93	0	0	10.8	0.1	1
2025	11	29	11	48	1	0	0	0	0	0	0	0	5.95	0	0	10.8	0.1	1
2025	11	29	11	58	1	0	0	0	0	0	0	0	5.97	0	0	10.8	0.1	1
2025	11	29	12	8	1	0	0	0	0	0	0	0	5.98	0	0	11	0.1	1
2025	11	29	12	18	1	0	0	0	0	0	0	0	6	0	0	11.4	0.1	1
2025	11	29	12	28	1	0	0	0	0	0	0	0	6.03	0	0	12.2	0.1	1
2025	11	29	12	38	1	0	0	0	0	0	0	0	6.06	0	0	12	0.1	1
2025	11	29	12	48	1	0	0	0	0	0	0	0	6.08	0	0	12	0.1	1
2025	11	29	12	58	1	0	0	0	0	0	0	0	6.1	0	0	12	0.1	1
2025	11	29	13	8	1	0	0	0	0	0	0	0	6.1	0	0	12	0.1	1
2025	11	29	13	18	1	0	0	0	0	0	0	0	6.11	0	0	12	0.1	1
2025	11	29	13	28	1	0	0	0	0	0	0	0	6.12	0	0	12	0.1	1
2025	11	29	13	38	1	0	0	0	0	0	0	0	6.14	0	0	12.4	0.1	1
2025	11	29	13	48	1	0	0	0	0	0	0	0	6.16	0	0	12.2	0.1	1
2025	11	29	13	58	1	0	0	0	0	0	0	0	6.18	0	0	12.4	0.1	1
2025	11	29	14	8	1	0	0	0	0	0	0	0	6.2	0	0	12.2	0.1	1
2025	11	29	14	18	1	0	0	0	0	0	0	0	6.2	0	0	12	0.1	1
2025	11	29	14	28	1	0	0	0	0	0	0	0	6.2	0	0	11.8	0.1	1
2025	11	29	14	38	1	0	0	0	0	0	0	0	6.19	0	0	11.8	0.1	1
2025	11	29	14	48	1	0	0	0	0	0	0	0	6.18	0	0	11.8	0.1	1
2025	11	29	14	58	1	0	0	0	0	0	0	0	6.17	0	0	11.8	0.1	1
2025	11	29	15	8	1	0	0	0	0	0	0	0	6.18	0	0	12	0.1	1
2025	11	29	15	18	1	0	0	0	0	0	0	0	6.19	0	0	12	0.1	1
2025	11	29	15	28	1	0	0	0	0	0	0	0	6.2	0	0	12	0.1	1
2025	11	29	15	38	1	0	0	0	0	0	0	0	6.2	0	0	12	0.1	1
2025	11	29	15	48	1	0	0	0	0	0	0	0	6.2	0	0	12	0.1	1
2025	11	29	15	58	1	0	0	0	0	0	0	0	6.2	0	0	11.8	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	29	16	8	1	0	0	0	0	0	0	0	6.19	0	0	11.8	0.1	1
2025	11	29	16	18	1	0	0	0	0	0	0	0	6.18	0	0	11.8	0.1	1
2025	11	29	16	28	1	0	0	0	0	0	0	0	6.17	0	0	11.8	0.1	1
2025	11	29	16	38	1	0	0	0	0	0	0	0	6.16	0	0	11.6	0.1	1
2025	11	29	16	48	1	0	0	0	0	0	0	0	6.16	0	0	11.6	0.1	1
2025	11	29	16	58	1	0	0	0	0	0	0	0	6.15	0	0	11.6	0.1	1
2025	11	29	17	8	1	0	0	0	0	0	0	0	6.15	0	0	11.4	0.1	1
2025	11	29	17	18	1	0	0	0	0	0	0	0	6.15	0	0	11.4	0.1	1
2025	11	29	17	28	1	0	0	0	0	0	0	0	6.13	0	0	11.4	0.1	1
2025	11	29	17	38	1	0	0	0	0	0	0	0	6.12	0	0	11.4	0.1	1
2025	11	29	17	48	1	0	0	0	0	0	0	0	6.11	0	0	11.4	0.1	1
2025	11	29	17	58	1	0	0	0	0	0	0	0	6.1	0	0	11.4	0.1	1
2025	11	29	18	8	1	0	0	0	0	0	0	0	6.09	0	0	11.4	0.1	1
2025	11	29	18	18	1	0	0	0	0	0	0	0	6.07	0	0	11.4	0.1	1
2025	11	29	18	28	1	0	0	0	0	0	0	0	6.06	0	0	11.4	0.1	1
2025	11	29	18	38	1	0	0	0	0	0	0	0	6.04	0	0	11.4	0.1	1
2025	11	29	18	48	1	0	0	0	0	0	0	0	6.02	0	0	11.4	0.1	1
2025	11	29	18	58	1	0	0	0	0	0	0	0	6	0	0	11.4	0.1	1
2025	11	29	19	8	1	0	0	0	0	0	0	0	5.99	0	0	11.4	0.1	1
2025	11	29	19	18	1	0	0	0	0	0	0	0	5.96	0	0	11.4	0.1	1
2025	11	29	19	28	1	0	0	0	0	0	0	0	5.95	0	0	11.4	0.1	1
2025	11	29	19	38	1	0	0	0	0	0	0	0	5.92	0	0	11.4	0.1	1
2025	11	29	19	48	1	0	0	0	0	0	0	0	5.9	0	0	11.4	0.1	1
2025	11	29	19	58	1	0	0	0	0	0	0	0	5.88	0	0	11.4	0.1	1
2025	11	29	20	8	1	0	0	0	0	0	0	0	5.85	0	0	11.4	0.1	1
2025	11	29	20	18	1	0	0	0	0	0	0	0	5.83	0	0	11.4	0.1	1
2025	11	29	20	28	1	0	0	0	0	0	0	0	5.81	0	0	11.4	0.1	1
2025	11	29	20	38	1	0	0	0	0	0	0	0	5.79	0	0	11.4	0.1	1
2025	11	29	20	48	1	0	0	0	0	0	0	0	5.76	0	0	11.4	0.1	1
2025	11	29	20	58	1	0	0	0	0	0	0	0	5.74	0	0	11.4	0.1	1
2025	11	29	21	8	1	0	0	0	0	0	0	0	5.71	0	0	11.4	0.1	1
2025	11	29	21	18	1	0	0	0	0	0	0	0	5.7	0	0	11.4	0.1	1
2025	11	29	21	28	1	0	0	0	0	0	0	0	5.68	0	0	11.4	0.1	1
2025	11	29	21	38	1	0	0	0	0	0	0	0	5.66	0	0	11.4	0.1	1
2025	11	29	21	48	1	0	0	0	0	0	0	0	5.64	0	0	11.4	0.1	1
2025	11	29	21	58	1	0	0	0	0	0	0	0	5.62	0	0	11.4	0.1	1
2025	11	29	22	8	1	0	0	0	0	0	0	0	5.6	0	0	11.2	0.1	1
2025	11	29	22	18	1	0	0	0	0	0	0	0	5.58	0	0	11.2	0.1	1
2025	11	29	22	28	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	29	22	38	1	0	0	0	0	0	0	0	5.55	0	0	11.2	0.1	1
2025	11	29	22	48	1	0	0	0	0	0	0	0	5.52	0	0	11.2	0.1	1
2025	11	29	22	58	1	0	0	0	0	0	0	0	5.51	0	0	11.2	0.1	1
2025	11	29	23	8	1	0	0	0	0	0	0	0	5.49	0	0	11.2	0.1	1
2025	11	29	23	18	1	0	0	0	0	0	0	0	5.47	0	0	11.2	0.1	1
2025	11	29	23	28	1	0	0	0	0	0	0	0	5.46	0	0	11.2	0.1	1
2025	11	29	23	38	1	0	0	0	0	0	0	0	5.44	0	0	11.2	0.1	1
2025	11	29	23	48	1	0	0	0	0	0	0	0	5.42	0	0	11.2	0.1	1
2025	11	29	23	58	1	0	0	0	0	0	0	0	5.4	0	0	11.2	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	30	0	8	1	0	0	0	0	0	0	0	5.39	0	0	11.2	0.1	1
2025	11	30	0	18	1	0	0	0	0	0	0	0	5.37	0	0	11.2	0.1	1
2025	11	30	0	28	1	0	0	0	0	0	0	0	5.36	0	0	11.2	0.1	1
2025	11	30	0	38	1	0	0	0	0	0	0	0	5.34	0	0	11.2	0.1	1
2025	11	30	0	48	1	0	0	0	0	0	0	0	5.33	0	0	11.2	0.1	1
2025	11	30	0	58	1	0	0	0	0	0	0	0	5.32	0	0	11.2	0.1	1
2025	11	30	1	8	1	0	0	0	0	0	0	0	5.31	0	0	11.2	0.1	1
2025	11	30	1	18	1	0	0	0	0	0	0	0	5.3	0	0	11.2	0.1	1
2025	11	30	1	28	1	0	0	0	0	0	0	0	5.29	0	0	11.2	0.1	1
2025	11	30	1	38	1	0	0	0	0	0	0	0	5.28	0	0	11.2	0.1	1
2025	11	30	1	48	1	0	0	0	0	0	0	0	5.27	0	0	11.2	0.1	1
2025	11	30	1	58	1	0	0	0	0	0	0	0	5.27	0	0	11.2	0.1	1
2025	11	30	2	8	1	0	0	0	0	0	0	0	5.26	0	0	11.2	0.1	1
2025	11	30	2	18	1	0	0	0	0	0	0	0	5.26	0	0	11.2	0.1	1
2025	11	30	2	28	1	0	0	0	0	0	0	0	5.26	0	0	11.2	0.1	1
2025	11	30	2	38	1	0	0	0	0	0	0	0	5.25	0	0	11.2	0.1	1
2025	11	30	2	48	1	0	0	0	0	0	0	0	5.25	0	0	11.2	0.1	1
2025	11	30	2	58	1	0	0	0	0	0	0	0	5.24	0	0	11.2	0.1	1
2025	11	30	3	8	1	0	0	0	0	0	0	0	5.24	0	0	11.2	0.1	1
2025	11	30	3	18	1	0	0	0	0	0	0	0	5.24	0	0	11.2	0.1	1
2025	11	30	3	28	1	0	0	0	0	0	0	0	5.24	0	0	11.2	0.1	1
2025	11	30	3	38	1	0	0	0	0	0	0	0	5.24	0	0	11.2	0.1	1
2025	11	30	3	48	1	0	0	0	0	0	0	0	5.24	0	0	11.2	0.1	1
2025	11	30	3	58	1	0	0	0	0	0	0	0	5.23	0	0	11.2	0.1	1
2025	11	30	4	8	1	0	0	0	0	0	0	0	5.23	0	0	11.2	0.1	1
2025	11	30	4	18	1	0	0	0	0	0	0	0	5.23	0	0	11.2	0.1	1
2025	11	30	4	28	1	0	0	0	0	0	0	0	5.23	0	0	11.2	0.1	1
2025	11	30	4	38	1	0	0	0	0	0	0	0	5.23	0	0	11.2	0.1	1
2025	11	30	4	48	1	0	0	0	0	0	0	0	5.23	0	0	11.2	0.1	1
2025	11	30	4	58	1	0	0	0	0	0	0	0	5.23	0	0	11.2	0.1	1
2025	11	30	5	8	1	0	0	0	0	0	0	0	5.23	0	0	11.2	0.1	1
2025	11	30	5	18	1	0	0	0	0	0	0	0	5.24	0	0	11.2	0.1	1
2025	11	30	5	28	1	0	0	0	0	0	0	0	5.23	0	0	11.2	0.1	1
2025	11	30	5	38	1	0	0	0	0	0	0	0	5.23	0	0	11.2	0.1	1
2025	11	30	5	48	1	0	0	0	0	0	0	0	5.23	0	0	11.2	0.1	1
2025	11	30	5	58	1	0	0	0	0	0	0	0	5.23	0	0	11.2	0.1	1
2025	11	30	6	8	1	0	0	0	0	0	0	0	5.23	0	0	11.2	0.1	1
2025	11	30	6	18	1	0	0	0	0	0	0	0	5.23	0	0	11.2	0.1	1
2025	11	30	6	28	1	0	0	0	0	0	0	0	5.23	0	0	11.2	0.1	1
2025	11	30	6	38	1	0	0	0	0	0	0	0	5.23	0	0	11.2	0.1	1
2025	11	30	6	48	1	0	0	0	0	0	0	0	5.24	0	0	11.2	0.1	1
2025	11	30	6	58	1	0	0	0	0	0	0	0	5.24	0	0	11	0.1	1
2025	11	30	7	8	1	0	0	0	0	0	0	0	5.24	0	0	11	0.1	1
2025	11	30	7	18	1	0	0	0	0	0	0	0	5.24	0	0	11	0.1	1
2025	11	30	7	28	1	0	0	0	0	0	0	0	5.24	0	0	11	0.1	1
2025	11	30	7	38	1	0	0	0	0	0	0	0	5.24	0	0	11	0.1	1
2025	11	30	7	48	1	0	0	0	0	0	0	0	5.25	0	0	11	0.1	1
2025	11	30	7	58	1	0	0	0	0	0	0	0	5.25	0	0	11	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	30	8	8	1	0	0	0	0	0	0	0	5.25	0	0	11	0.1	1
2025	11	30	8	18	1	0	0	0	0	0	0	0	5.25	0	0	11	0.1	1
2025	11	30	8	28	1	0	0	0	0	0	0	0	5.25	0	0	11	0.1	1
2025	11	30	8	38	1	0	0	0	0	0	0	0	5.25	0	0	11	0.1	1
2025	11	30	8	48	1	0	0	0	0	0	0	0	5.26	0	0	11	0.1	1
2025	11	30	8	58	1	0	0	0	0	0	0	0	5.26	0	0	11	0.1	1
2025	11	30	9	8	1	0	0	0	0	0	0	0	5.27	0	0	11	0.1	1
2025	11	30	9	18	1	0	0	0	0	0	0	0	5.28	0	0	11.2	0.1	1
2025	11	30	9	28	1	0	0	0	0	0	0	0	5.29	0	0	11.6	0.1	1
2025	11	30	9	38	1	0	0	0	0	0	0	0	5.31	0	0	12	0.1	1
2025	11	30	9	48	1	0	0	0	0	0	0	0	5.34	0	0	12	0.1	1
2025	11	30	9	58	1	0	0	0	0	0	0	0	5.36	0	0	11.6	0.1	1
2025	11	30	10	8	1	0	0	0	0	0	0	0	5.36	0	0	11.8	0.1	1
2025	11	30	10	18	1	0	0	0	0	0	0	0	5.38	0	0	12.2	0.1	1
2025	11	30	10	28	1	0	0	0	0	0	0	0	5.41	0	0	12	0.1	1
2025	11	30	10	38	1	0	0	0	0	0	0	0	5.42	0	0	11.6	0.1	1
2025	11	30	10	48	1	0	0	0	0	0	0	0	5.43	0	0	12.4	0.1	1
2025	11	30	10	58	1	0	0	0	0	0	0	0	5.47	0	0	12.2	0.1	1
2025	11	30	11	8	1	0	0	0	0	0	0	0	5.49	0	0	11.8	0.1	1
2025	11	30	11	18	1	0	0	0	0	0	0	0	5.49	0	0	12	0.1	1
2025	11	30	11	28	1	0	0	0	0	0	0	0	5.52	0	0	11.8	0.1	1
2025	11	30	11	38	1	0	0	0	0	0	0	0	5.52	0	0	11.8	0.1	1
2025	11	30	11	48	1	0	0	0	0	0	0	0	5.54	0	0	12	0.1	1
2025	11	30	11	58	1	0	0	0	0	0	0	0	5.56	0	0	11.8	0.1	1
2025	11	30	12	8	1	0	0	0	0	0	0	0	5.58	0	0	11.8	0.1	1
2025	11	30	12	18	1	0	0	0	0	0	0	0	5.59	0	0	12	0.1	1
2025	11	30	12	28	1	0	0	0	0	0	0	0	5.61	0	0	12	0.1	1
2025	11	30	12	38	1	0	0	0	0	0	0	0	5.62	0	0	11.8	0.1	1
2025	11	30	12	48	1	0	0	0	0	0	0	0	5.63	0	0	12.2	0.1	1
2025	11	30	12	58	1	0	0	0	0	0	0	0	5.64	0	0	11.6	0.1	1
2025	11	30	13	8	1	0	0	0	0	0	0	0	5.64	0	0	11.6	0.1	1
2025	11	30	13	18	1	0	0	0	0	0	0	0	5.64	0	0	11.8	0.1	1
2025	11	30	13	28	1	0	0	0	0	0	0	0	5.65	0	0	11.8	0.1	1
2025	11	30	13	38	1	0	0	0	0	0	0	0	5.66	0	0	12	0.1	1
2025	11	30	13	48	1	0	0	0	0	0	0	0	5.68	0	0	12.2	0.1	1
2025	11	30	13	58	1	0	0	0	0	0	0	0	5.71	0	0	12.2	0.1	1
2025	11	30	14	8	1	0	0	0	0	0	0	0	5.73	0	0	12.2	0.1	1
2025	11	30	14	18	1	0	0	0	0	0	0	0	5.75	0	0	12.2	0.1	1
2025	11	30	14	28	1	0	0	0	0	0	0	0	5.76	0	0	12.2	0.1	1
2025	11	30	14	38	1	0	0	0	0	0	0	0	5.77	0	0	12	0.1	1
2025	11	30	14	48	1	0	0	0	0	0	0	0	5.77	0	0	12	0.1	1
2025	11	30	14	58	1	0	0	0	0	0	0	0	5.77	0	0	12	0.1	1
2025	11	30	15	8	1	0	0	0	0	0	0	0	5.77	0	0	12	0.1	1
2025	11	30	15	18	1	0	0	0	0	0	0	0	5.77	0	0	12	0.1	1
2025	11	30	15	28	1	0	0	0	0	0	0	0	5.77	0	0	11.8	0.1	1
2025	11	30	15	38	1	0	0	0	0	0	0	0	5.76	0	0	11.8	0.1	1
2025	11	30	15	48	1	0	0	0	0	0	0	0	5.75	0	0	11.8	0.1	1
2025	11	30	15	58	1	0	0	0	0	0	0	0	5.75	0	0	11.8	0.1	1

Reinhackle (0365)																		
Year	Month	Day	Hour	Minute	Second	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage	CellBegin	CellEnd
2025	11	30	16	8	1	0	0	0	0	0	0	0	5.74	0	0	11.8	0.1	1
2025	11	30	16	18	1	0	0	0	0	0	0	0	5.73	0	0	11.8	0.1	1
2025	11	30	16	28	1	0	0	0	0	0	0	0	5.72	0	0	11.6	0.1	1
2025	11	30	16	38	1	0	0	0	0	0	0	0	5.72	0	0	11.6	0.1	1
2025	11	30	16	48	1	0	0	0	0	0	0	0	5.71	0	0	11.4	0.1	1
2025	11	30	16	58	1	0	0	0	0	0	0	0	5.71	0	0	11.4	0.1	1
2025	11	30	17	8	1	0	0	0	0	0	0	0	5.7	0	0	11.4	0.1	1
2025	11	30	17	18	1	0	0	0	0	0	0	0	5.7	0	0	11.4	0.1	1
2025	11	30	17	28	1	0	0	0	0	0	0	0	5.69	0	0	11.4	0.1	1
2025	11	30	17	38	1	0	0	0	0	0	0	0	5.68	0	0	11.4	0.1	1
2025	11	30	17	48	1	0	0	0	0	0	0	0	5.68	0	0	11.4	0.1	1
2025	11	30	17	58	1	0	0	0	0	0	0	0	5.67	0	0	11.4	0.1	1
2025	11	30	18	8	1	0	0	0	0	0	0	0	5.66	0	0	11.4	0.1	1
2025	11	30	18	18	1	0	0	0	0	0	0	0	5.65	0	0	11.4	0.1	1
2025	11	30	18	28	1	0	0	0	0	0	0	0	5.64	0	0	11.4	0.1	1
2025	11	30	18	38	1	0	0	0	0	0	0	0	5.62	0	0	11.4	0.1	1
2025	11	30	18	48	1	0	0	0	0	0	0	0	5.61	0	0	11.4	0.1	1
2025	11	30	18	58	1	0	0	0	0	0	0	0	5.59	0	0	11.2	0.1	1
2025	11	30	19	8	1	0	0	0	0	0	0	0	5.57	0	0	11.2	0.1	1
2025	11	30	19	18	1	0	0	0	0	0	0	0	5.56	0	0	11.2	0.1	1
2025	11	30	19	28	1	0	0	0	0	0	0	0	5.53	0	0	11.2	0.1	1
2025	11	30	19	38	1	0	0	0	0	0	0	0	5.52	0	0	11.2	0.1	1
2025	11	30	19	48	1	0	0	0	0	0	0	0	5.5	0	0	11.2	0.1	1
2025	11	30	19	58	1	0	0	0	0	0	0	0	5.48	0	0	11.2	0.1	1
2025	11	30	20	8	1	0	0	0	0	0	0	0	5.46	0	0	11.2	0.1	1
2025	11	30	20	18	1	0	0	0	0	0	0	0	5.43	0	0	11.2	0.1	1
2025	11	30	20	28	1	0	0	0	0	0	0	0	5.42	0	0	11.2	0.1	1
2025	11	30	20	38	1	0	0	0	0	0	0	0	5.4	0	0	11.2	0.1	1
2025	11	30	20	48	1	0	0	0	0	0	0	0	5.38	0	0	11.2	0.1	1
2025	11	30	20	58	1	0	0	0	0	0	0	0	5.37	0	0	11.2	0.1	1
2025	11	30	21	8	1	0	0	0	0	0	0	0	5.35	0	0	11.2	0.1	1
2025	11	30	21	18	1	0	0	0	0	0	0	0	5.33	0	0	11.2	0.1	1
2025	11	30	21	28	1	0	0	0	0	0	0	0	5.31	0	0	11.2	0.1	1
2025	11	30	21	38	1	0	0	0	0	0	0	0	5.3	0	0	11.2	0.1	1
2025	11	30	21	48	1	0	0	0	0	0	0	0	5.28	0	0	11.2	0.1	1
2025	11	30	21	58	1	0	0	0	0	0	0	0	5.26	0	0	11.2	0.1	1
2025	11	30	22	8	1	0	0	0	0	0	0	0	5.24	0	0	11.2	0.1	1
2025	11	30	22	18	1	0	0	0	0	0	0	0	5.23	0	0	11.2	0.1	1
2025	11	30	22	28	1	0	0	0	0	0	0	0	5.21	0	0	11.2	0.1	1
2025	11	30	22	38	1	0	0	0	0	0	0	0	5.2	0	0	11.2	0.1	1
2025	11	30	22	48	1	0	0	0	0	0	0	0	5.18	0	0	11.2	0.1	1
2025	11	30	22	58	1	0	0	0	0	0	0	0	5.16	0	0	11.2	0.1	1
2025	11	30	23	8	1	0	0	0	0	0	0	0	5.14	0	0	11.2	0.1	1
2025	11	30	23	18	1	0	0	0	0	0	0	0	5.12	0	0	11.2	0.1	1
2025	11	30	23	28	1	0	0	0	0	0	0	0	5.11	0	0	11.2	0.1	1
2025	11	30	23	38	1	0	0	0	0	0	0	0	5.09	0	0	11.2	0.1	1
2025	11	30	23	48	1	0	0	0	0	0	0	0	5.08	0	0	11.2	0.1	1
2025	11	30	23	58	1	0	0	0	0	0	0	0	5.06	0	0	11.2	0.1	1

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	1	0	2	15	24.86	96.5	6.8482	56.5002
2025	11	1	0	12	15	25.08	96.9	6.8482	56.9577
2025	11	1	0	22	15	24.87	96.7	6.8421	56.4476
2025	11	1	0	32	15	25.16	96.4	6.8421	57.1332
2025	11	1	0	42	15	25.03	97.8	6.8421	56.6762
2025	11	1	0	52	15	25.79	96.9	6.8421	58.5044
2025	11	1	1	2	15	26.04	96	6.8482	59.2453
2025	11	1	1	12	15	25.58	98.5	6.8421	57.8188
2025	11	1	1	22	15	25.62	95.6	6.8421	58.2759
2025	11	1	1	32	15	24.86	96.5	6.8421	56.4477
2025	11	1	1	42	15	25.96	96.4	6.8421	58.9615
2025	11	1	1	52	15	24.66	94	6.8421	56.2191
2025	11	1	2	2	15	25.71	97.4	6.8421	58.2759
2025	11	1	2	12	15	25.23	95.9	6.8421	57.3618
2025	11	1	2	22	15	24.32	95.7	6.8421	55.305
2025	11	1	2	32	15	25.26	98.2	6.8421	57.1333
2025	11	1	2	42	15	25.36	98.2	6.8421	57.3618
2025	11	1	2	52	15	25.75	96.2	6.8421	58.5045
2025	11	1	3	2	15	24.72	97.7	6.8421	55.9906
2025	11	1	3	12	15	25.42	97.5	6.8421	57.5903
2025	11	1	3	22	15	25.75	96.2	6.8421	58.5045
2025	11	1	3	32	15	25.29	98.6	6.8421	57.1333
2025	11	1	3	42	15	24.61	97.5	6.8421	55.7621
2025	11	1	3	52	15	25.79	96.9	6.8421	58.5045
2025	11	1	4	2	15	25.92	95.5	6.8421	58.9615
2025	11	1	4	12	15	24.29	97.1	6.8421	55.0765
2025	11	1	4	22	15	25.38	96.8	6.8421	57.5903
2025	11	1	4	32	15	25.78	98.5	6.8421	58.2759
2025	11	1	4	42	15	25.4	97.2	6.8421	57.5903
2025	11	1	4	52	15	24.81	97.4	6.8421	56.2191
2025	11	1	5	2	15	24.8	95.1	6.8421	56.4476
2025	11	1	5	12	15	25.32	95.7	6.8421	57.5903
2025	11	1	5	22	15	25.21	95.2	6.8421	57.3618
2025	11	1	5	32	15	25.93	95.8	6.8421	58.9615
2025	11	1	5	42	15	23.78	97	6.8421	53.9338
2025	11	1	5	52	15	25.37	96.6	6.8421	57.5903
2025	11	1	6	2	15	25.04	93.4	6.8421	57.1332
2025	11	1	6	12	15	24.25	98.3	6.8482	54.899
2025	11	1	6	22	15	24.88	96.9	6.8482	56.5003
2025	11	1	6	32	15	25.51	97.4	6.8421	57.8188
2025	11	1	6	42	15	26.06	96.4	6.8421	59.19
2025	11	1	6	52	15	25.99	96.9	6.8482	59.0165
2025	11	1	7	2	15	24.97	99.9	6.8482	56.2715
2025	11	1	7	12	15	25.26	96.4	6.8482	57.4152
2025	11	1	7	22	15	24.43	95.9	6.8482	55.5853
2025	11	1	7	32	15	25.73	95.8	6.8482	58.559
2025	11	1	7	42	15	24.31	97.6	6.8482	55.1278
2025	11	1	7	52	15	24.29	95	6.8482	55.3565

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	1	8	2	15	24.73	97.9	6.8543	56.095
2025	11	1	8	12	15	25.7	95.1	6.8543	58.6135
2025	11	1	8	22	15	25.6	97.2	6.8543	58.1556
2025	11	1	8	32	15	25.23	95.9	6.8543	57.4687
2025	11	1	8	42	15	25.34	96.1	6.8543	57.6976
2025	11	1	8	52	15	24.89	98.8	6.8543	56.3238
2025	11	1	9	2	15	26.21	97.2	6.8482	59.4738
2025	11	1	9	12	15	25.1	97.3	6.8543	57.0106
2025	11	1	9	22	15	23.93	92.9	6.8543	54.721
2025	11	1	9	32	15	25.3	98.9	6.8543	57.2395
2025	11	1	9	42	15	25.8	97.1	6.8604	58.6677
2025	11	1	9	52	15	24.17	98.6	6.8543	54.7209
2025	11	1	10	2	15	25.45	96.3	6.8543	57.9262
2025	11	1	10	12	15	25.47	96.5	6.8604	57.9801
2025	11	1	10	22	15	26.01	97.3	6.8543	59.0709
2025	11	1	10	32	15	25.48	96.8	6.8543	57.9261
2025	11	1	10	42	15	25.33	95.9	6.8543	57.6971
2025	11	1	10	52	15	25.64	97.8	6.8543	58.155
2025	11	1	11	2	15	24.24	98.1	6.8543	54.9495
2025	11	1	11	12	15	25.01	97.4	6.8543	56.7812
2025	11	1	11	22	15	24.19	97.1	6.8543	54.9495
2025	11	1	11	32	15	24.38	98.7	6.8604	55.2298
2025	11	1	11	42	15	26.17	96.6	6.8604	59.584
2025	11	1	11	52	15	25.58	96.7	6.8604	58.2089
2025	11	1	12	2	15	25.6	97.2	6.8604	58.2089
2025	11	1	12	12	15	24.94	96	6.8604	56.8338
2025	11	1	12	22	15	25.96	96.4	6.8604	59.1255
2025	11	1	12	32	15	25.42	97.5	6.8604	57.7505
2025	11	1	12	42	15	25.34	97.9	6.8604	57.5213
2025	11	1	12	52	15	24.78	94.6	6.8604	56.6046
2025	11	1	13	2	15	25.26	98.2	6.8604	57.2921
2025	11	1	13	12	15	26.16	98.1	6.8604	59.3546
2025	11	1	13	22	15	24.76	98.4	6.8604	56.1463
2025	11	1	13	32	15	24.21	97.6	6.8604	55.0004
2025	11	1	13	42	15	24.85	98.1	6.8604	56.3754
2025	11	1	13	52	15	26.63	97.6	6.8604	60.5004
2025	11	1	14	2	15	25.06	96.4	6.8604	57.0629
2025	11	1	14	12	15	24.92	95.5	6.8604	56.8338
2025	11	1	14	22	15	23.8	97.5	6.8604	54.0837
2025	11	1	14	32	15	26.08	96.8	6.8604	59.3546
2025	11	1	14	42	15	23.83	96	6.8604	54.3129
2025	11	1	14	52	15	24.72	97.7	6.8543	56.0941
2025	11	1	15	2	15	24.18	94.7	6.8543	55.1783
2025	11	1	15	12	15	23.64	96.3	6.8543	53.8045
2025	11	1	15	22	15	24.35	96.4	6.8543	55.4072
2025	11	1	15	32	15	25.07	94.3	6.8543	57.2389
2025	11	1	15	42	15	24.42	97.8	6.8543	55.4073
2025	11	1	15	52	15	24.88	96.9	6.8604	56.6048

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	1	16	2	15	24.76	98.4	6.8543	56.0942
2025	11	1	16	12	15	25.48	96.8	6.8543	57.9259
2025	11	1	16	22	15	25.63	95.8	6.8543	58.3838
2025	11	1	16	32	15	25.03	97.8	6.8543	56.7812
2025	11	1	16	42	15	24.68	98.6	6.8543	55.8653
2025	11	1	16	52	15	26.3	97	6.8543	59.7576
2025	11	1	17	2	15	25.27	96.6	6.8543	57.468
2025	11	1	17	12	15	25.84	97.8	6.8543	58.6128
2025	11	1	17	22	15	25.87	96.7	6.8543	58.8418
2025	11	1	17	32	15	25.5	95.2	6.8543	58.1549
2025	11	1	17	42	15	24.83	95.8	6.8543	56.5523
2025	11	1	17	52	15	24.67	94.4	6.8543	56.3233
2025	11	1	18	2	15	23.94	96.2	6.8543	54.4917
2025	11	1	18	12	15	25.97	96.6	6.8543	59.0708
2025	11	1	18	22	15	25.69	96.9	6.8543	58.384
2025	11	1	18	32	15	26.93	97.5	6.8543	61.1315
2025	11	1	18	42	15	24.14	96.2	6.8543	54.9496
2025	11	1	18	52	15	25.84	99.4	6.8543	58.384
2025	11	1	19	2	15	25.84	97.8	6.8543	58.613
2025	11	1	19	12	15	24.75	96.3	6.8543	56.3234
2025	11	1	19	22	15	25.68	96.7	6.8543	58.3841
2025	11	1	19	32	15	26.25	97.9	6.8543	59.5289
2025	11	1	19	42	15	26.51	97.2	6.8604	60.2719
2025	11	1	19	52	15	25.48	96.8	6.8604	57.9802
2025	11	1	20	2	15	26.32	99	6.8604	59.5844
2025	11	1	20	12	15	25.42	97.5	6.8604	57.7511
2025	11	1	20	22	15	24.96	98.3	6.8604	56.6052
2025	11	1	20	32	15	25.9	97.1	6.8604	58.897
2025	11	1	20	42	15	24.98	96.9	6.8604	56.8344
2025	11	1	20	52	15	26.05	97.9	6.8604	59.1262
2025	11	1	21	2	15	25.03	95.7	6.8604	57.0637
2025	11	1	21	12	15	25.99	96.9	6.8665	59.1812
2025	11	1	21	22	15	24.27	94.3	6.8665	55.5111
2025	11	1	21	32	15	25.48	98.6	6.8665	57.805
2025	11	1	21	42	15	24.84	96	6.8665	56.6581
2025	11	1	21	52	15	25.45	99.5	6.8665	57.5756
2025	11	1	22	2	15	25.74	97.8	6.8665	58.4932
2025	11	1	22	12	15	26.16	98.1	6.8665	59.4108
2025	11	1	22	22	15	26.26	96.3	6.8604	59.8139
2025	11	1	22	32	15	27.01	97.2	6.8665	61.4753
2025	11	1	22	42	15	25.2	95	6.8665	57.5757
2025	11	1	22	52	15	25.47	98.4	6.8665	57.8051
2025	11	1	23	2	15	24.7	97.2	6.8665	56.1995
2025	11	1	23	12	15	26.06	96.4	6.8665	59.4109
2025	11	1	23	22	15	24.92	97.6	6.8665	56.6583
2025	11	1	23	32	15	26.32	95.5	6.8665	60.0991
2025	11	1	23	42	15	25.23	95.9	6.8665	57.5759
2025	11	1	23	52	15	26.32	97.4	6.8665	59.8697

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	2	0	2	15	24.79	97.2	6.8665	56.429
2025	11	2	0	12	15	24.37	96.8	6.8665	55.5114
2025	11	2	0	22	15	25.96	96.4	6.8665	59.1816
2025	11	2	0	32	15	25.6	97.2	6.8665	58.2641
2025	11	2	0	42	15	25.42	95.6	6.8665	58.0347
2025	11	2	0	52	15	25.86	96.4	6.8665	58.9523
2025	11	2	1	2	15	25.93	95.8	6.8665	59.1817
2025	11	2	1	12	15	25.65	98.1	6.8665	58.2641
2025	11	2	1	22	15	25.91	97.3	6.8665	58.9523
2025	11	2	1	32	15	25.21	95.2	6.8665	57.576
2025	11	2	1	42	15	25.22	97.5	6.8665	57.3466
2025	11	2	1	52	15	25.14	98	6.8665	57.1172
2025	11	2	2	2	15	24.57	96.8	6.8665	55.9703
2025	11	2	2	12	15	25.38	96.8	6.8665	57.8054
2025	11	2	2	22	15	24.67	96.8	6.8665	56.1997
2025	11	2	2	32	15	25.2	97.3	6.8665	57.3466
2025	11	2	2	42	15	25.4	95.2	6.8665	58.0348
2025	11	2	2	52	15	25.08	96.9	6.8665	57.1172
2025	11	2	3	2	15	26.09	98.6	6.8665	59.1817
2025	11	2	3	12	15	25.96	96.4	6.8665	59.1817
2025	11	2	3	22	15	23.55	98.3	6.8665	53.447
2025	11	2	3	32	15	25.52	95.6	6.8665	58.2641
2025	11	2	3	42	15	25.07	96.6	6.8665	57.1172
2025	11	2	3	52	15	24.61	99.1	6.8665	55.7409
2025	11	2	4	2	15	25.7	97.2	6.8665	58.4935
2025	11	2	4	12	15	25.23	95.9	6.8665	57.576
2025	11	2	4	22	15	24.99	97.1	6.8665	56.8878
2025	11	2	4	32	15	23.4	95.4	6.8665	53.447
2025	11	2	4	42	15	25.53	97.7	6.8665	58.0347
2025	11	2	4	52	15	25.23	92.7	6.8665	57.8053
2025	11	2	5	2	15	25.43	99.3	6.8665	57.5759
2025	11	2	5	12	15	25.03	95.7	6.8665	57.1172
2025	11	2	5	22	15	25.73	95.8	6.8665	58.7229
2025	11	2	5	32	15	26.35	97.9	6.8665	59.8698
2025	11	2	5	42	15	24.06	98.4	6.8665	54.5939
2025	11	2	5	52	15	24.91	95.3	6.8665	56.8878
2025	11	2	6	2	15	24.73	95.8	6.8665	56.429
2025	11	2	6	12	15	25.27	96.6	6.8665	57.5759
2025	11	2	6	22	15	25.15	96.2	6.8665	57.3465
2025	11	2	6	32	15	24.37	96.8	6.8665	55.5114
2025	11	2	6	42	15	24.59	94.9	6.8665	56.1996
2025	11	2	6	52	15	25.59	97	6.8665	58.2641
2025	11	2	7	2	15	25.19	98.7	6.8665	57.1171
2025	11	2	7	12	15	25.87	98.2	6.8665	58.7228
2025	11	2	7	22	15	24.37	96.8	6.8665	55.5114
2025	11	2	7	32	15	24.63	95.8	6.8665	56.1996
2025	11	2	7	42	15	26.03	95.7	6.8665	59.411
2025	11	2	7	52	15	25.6	95.2	6.8665	58.4934

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	2	8	2	15	25.26	96.4	6.8665	57.5759
2025	11	2	8	12	15	26.07	96.6	6.8665	59.411
2025	11	2	8	22	15	24.79	97.2	6.8665	56.4289
2025	11	2	8	32	15	25.71	97.4	6.8665	58.4934
2025	11	2	8	42	15	24.48	98.7	6.8726	55.5629
2025	11	2	8	52	15	25.88	98.4	6.8726	58.7773
2025	11	2	9	2	15	24.43	95.9	6.8665	55.7406
2025	11	2	9	12	15	25.92	95.5	6.8726	59.2364
2025	11	2	9	22	15	25.27	96.6	6.8726	57.6291
2025	11	2	9	32	15	25.13	95.9	6.8726	57.3995
2025	11	2	9	42	15	24.89	97.2	6.8726	56.7107
2025	11	2	9	52	15	25.28	96.8	6.8726	57.629
2025	11	2	10	2	15	25.63	99.2	6.8726	58.0882
2025	11	2	10	12	15	24.95	98.1	6.8726	56.7106
2025	11	2	10	22	15	24.85	98.1	6.8726	56.4809
2025	11	2	10	32	15	26.1	97	6.8726	59.4656
2025	11	2	10	42	15	25.81	95.3	6.8726	59.0064
2025	11	2	10	52	15	25.05	96.2	6.8726	57.1696
2025	11	2	11	2	15	25.06	98.3	6.8726	56.94
2025	11	2	11	12	15	26.66	96.2	6.8726	60.8431
2025	11	2	11	22	15	25.03	95.7	6.8726	57.1695
2025	11	2	11	32	15	25.75	98	6.8726	58.5471
2025	11	2	11	42	15	25.69	96.9	6.8726	58.5471
2025	11	2	11	52	15	24.98	96.9	6.8726	56.9398
2025	11	2	12	2	15	26.02	99.1	6.8726	59.0063
2025	11	2	12	12	15	25.05	96.2	6.8726	57.1694
2025	11	2	12	22	15	25.82	95.6	6.8726	59.0062
2025	11	2	12	32	15	26.87	98.1	6.8726	61.0727
2025	11	2	12	42	15	25.84	96	6.8665	58.9515
2025	11	2	12	52	15	24.14	96.2	6.8604	55.0008
2025	11	2	13	2	15	25.23	95.9	6.8665	57.5751
2025	11	2	13	12	15	25.23	95.9	6.8604	57.5216
2025	11	2	13	22	15	24.69	94.9	6.8604	56.3757
2025	11	2	13	32	15	24.15	96.4	6.8604	55.0007
2025	11	2	13	42	15	24.86	96.5	6.8604	56.6049
2025	11	2	13	52	15	25.41	95.4	6.8604	57.9799
2025	11	2	14	2	15	25.22	97.5	6.8604	57.2923
2025	11	2	14	12	15	24.98	94.6	6.8604	57.0632
2025	11	2	14	22	15	24.36	96.6	6.8604	55.4589
2025	11	2	14	32	15	24.06	96.7	6.8604	54.7714
2025	11	2	14	42	15	24.67	96.8	6.8665	56.1987
2025	11	2	14	52	15	25.04	96	6.8604	57.0631
2025	11	2	15	2	15	25.12	92.5	6.8604	57.5215
2025	11	2	15	12	15	24.48	97	6.8604	55.6882
2025	11	2	15	22	15	24.74	96	6.8665	56.4281
2025	11	2	15	32	15	24.22	99.3	6.8604	54.7715
2025	11	2	15	42	15	25.49	94.7	6.8604	58.2091
2025	11	2	15	52	15	24.28	94.7	6.8604	55.4591

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	2	16	2	15	23.89	97.2	6.8543	54.2628
2025	11	2	16	12	15	24.75	96.3	6.8604	56.3758
2025	11	2	16	22	15	24.69	94.9	6.8543	56.3234
2025	11	2	16	32	15	25.64	97.8	6.8543	58.1551
2025	11	2	16	42	15	24.64	97.9	6.8543	55.8655
2025	11	2	16	52	15	25.45	96.3	6.8543	57.9261
2025	11	2	17	2	15	25.69	96.9	6.8543	58.384
2025	11	2	17	12	15	25.9	97.1	6.8543	58.842
2025	11	2	17	22	15	26.48	96.7	6.8543	60.2157
2025	11	2	17	32	15	25.52	95.6	6.8543	58.1551
2025	11	2	17	42	15	27.07	96.4	6.8604	61.6468
2025	11	2	17	52	15	26.35	97.9	6.8543	59.7579
2025	11	2	18	2	15	25.13	95.9	6.8543	57.2393
2025	11	2	18	12	15	26.27	96.6	6.8604	59.8135
2025	11	2	18	22	15	25.58	98.5	6.8604	57.9802
2025	11	2	18	32	15	27	97	6.8604	61.4177
2025	11	2	18	42	15	25.99	96.9	6.8543	59.0711
2025	11	2	18	52	15	25.62	95.6	6.8604	58.4386
2025	11	2	19	2	15	26.21	97.2	6.8604	59.5844
2025	11	2	19	12	15	26.6	95	6.8604	60.7303
2025	11	2	19	22	15	24.54	96.1	6.8604	55.9177
2025	11	2	19	32	15	26.29	98.5	6.8604	59.5845
2025	11	2	19	42	15	24.83	97.9	6.8665	56.4286
2025	11	2	19	52	15	24.31	97.6	6.8665	55.2817
2025	11	2	20	2	15	24.91	95.3	6.8604	56.8345
2025	11	2	20	12	15	24.82	95.5	6.8604	56.6054
2025	11	2	20	22	15	25.37	96.6	6.8665	57.805
2025	11	2	20	32	15	25.58	96.7	6.8665	58.2638
2025	11	2	20	42	15	25.39	98.6	6.8665	57.5756
2025	11	2	20	52	15	27.04	97.7	6.8665	61.4752
2025	11	2	21	2	15	24.81	97.4	6.8665	56.4288
2025	11	2	21	12	15	24.55	96.3	6.8665	55.97
2025	11	2	21	22	15	25.79	96.9	6.8665	58.7227
2025	11	2	21	32	15	25.16	96.4	6.8665	57.3464
2025	11	2	21	42	15	25.78	99.8	6.8665	58.2639
2025	11	2	21	52	15	24.81	99	6.8665	56.1995
2025	11	2	22	2	15	25.77	98.3	6.8665	58.4934
2025	11	2	22	12	15	25.21	95.2	6.8665	57.5759
2025	11	2	22	22	15	26.99	96.8	6.8665	61.4754
2025	11	2	22	32	15	26.02	97.5	6.8665	59.1816
2025	11	2	22	42	15	25.38	96.8	6.8665	57.8053
2025	11	2	22	52	15	24.7	97.2	6.8665	56.1996
2025	11	2	23	2	15	24.82	97.6	6.8665	56.429
2025	11	2	23	12	15	24.14	96.2	6.8665	55.0527
2025	11	2	23	22	15	24.74	96	6.8665	56.4291
2025	11	2	23	32	15	25.16	96.4	6.8665	57.3466
2025	11	2	23	42	15	25.6	98.8	6.8665	58.0348
2025	11	2	23	52	15	25.74	97.8	6.8665	58.4936

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	3	0	2	15	25.47	96.5	6.8665	58.0348
2025	11	3	0	12	15	25.17	96.6	6.8665	57.3467
2025	11	3	0	22	15	24.52	95.6	6.8665	55.9704
2025	11	3	0	32	15	25.68	98.5	6.8665	58.2642
2025	11	3	0	42	15	24.53	95.9	6.8665	55.9704
2025	11	3	0	52	15	25.55	96.3	6.8665	58.2643
2025	11	3	1	2	15	25.58	96.7	6.8665	58.2643
2025	11	3	1	12	15	25.68	96.7	6.8665	58.4937
2025	11	3	1	22	15	24.66	96.5	6.8604	56.1476
2025	11	3	1	32	15	24.99	94.8	6.8604	57.0643
2025	11	3	1	42	15	25.57	96.5	6.8604	58.2102
2025	11	3	1	52	15	24.79	97.2	6.8665	56.4292
2025	11	3	2	2	15	24.52	95.6	6.8665	55.9704
2025	11	3	2	12	15	25.03	95.7	6.8665	57.1174
2025	11	3	2	22	15	24.19	95	6.8665	55.2823
2025	11	3	2	32	15	24.71	97.4	6.8604	56.1476
2025	11	3	2	42	15	25.03	95.7	6.8604	57.0643
2025	11	3	2	52	15	25.94	96	6.8604	59.1269
2025	11	3	3	2	15	24.96	96.4	6.8604	56.8351
2025	11	3	3	12	15	23.36	96.6	6.8604	53.1683
2025	11	3	3	22	15	25.26	96.4	6.8604	57.5226
2025	11	3	3	32	15	25.33	97.7	6.8604	57.5226
2025	11	3	3	42	15	25.43	95.9	6.8604	57.981
2025	11	3	3	52	15	25.47	96.5	6.8604	57.981
2025	11	3	4	2	15	25.08	96.9	6.8604	57.0643
2025	11	3	4	12	15	25.09	94.8	6.8604	57.2935
2025	11	3	4	22	15	25.76	96.5	6.8604	58.6685
2025	11	3	4	32	15	26.47	98.3	6.8604	60.0435
2025	11	3	4	42	15	24.45	98.2	6.8604	55.4601
2025	11	3	4	52	15	25.4	97.2	6.8604	57.7518
2025	11	3	5	2	15	25.96	96.4	6.8604	59.1268
2025	11	3	5	12	15	26.42	97.4	6.8604	60.0435
2025	11	3	5	22	15	25.68	98.5	6.8604	58.2101
2025	11	3	5	32	15	25.33	97.7	6.8665	57.5761
2025	11	3	5	42	15	25.59	97	6.8665	58.2643
2025	11	3	5	52	15	24.31	95.4	6.8665	55.5116
2025	11	3	6	2	15	25.93	95.8	6.8604	59.1268
2025	11	3	6	12	15	25.76	96.5	6.8665	58.723
2025	11	3	6	22	15	24.72	97.7	6.8665	56.1998
2025	11	3	6	32	15	26.11	97.3	6.8665	59.4112
2025	11	3	6	42	15	25.06	98.3	6.8665	56.8879
2025	11	3	6	52	15	25.1	95	6.8665	57.3467
2025	11	3	7	2	15	24.36	96.6	6.8665	55.5116
2025	11	3	7	12	15	25.61	99	6.8665	58.0349
2025	11	3	7	22	15	24.83	95.8	6.8665	56.6585
2025	11	3	7	32	15	24.42	97.8	6.8665	55.5116
2025	11	3	7	42	15	27.94	95.8	6.8665	63.7695
2025	11	3	7	52	15	24.71	95.3	6.8665	56.4291

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	3	8	2	15	24.37	96.8	6.8665	55.5116
2025	11	3	8	12	15	25.71	97.4	6.8665	58.4936
2025	11	3	8	22	15	24.8	95.1	6.8665	56.6585
2025	11	3	8	32	15	24.73	95.8	6.8665	56.4291
2025	11	3	8	42	15	25.08	96.9	6.8665	57.1172
2025	11	3	8	52	15	26.61	97.1	6.8665	60.558
2025	11	3	9	2	15	25.18	96.8	6.8665	57.3465
2025	11	3	9	12	15	25.08	94.6	6.8665	57.3465
2025	11	3	9	22	15	26.28	96.8	6.8665	59.8697
2025	11	3	9	32	15	26.61	95.2	6.8726	60.8437
2025	11	3	9	42	15	25.84	96	6.8726	59.0069
2025	11	3	9	52	15	26.47	96.5	6.8726	60.3844
2025	11	3	10	2	15	25.59	94.9	6.8726	58.5476
2025	11	3	10	12	15	24.7	97.2	6.8726	56.2516
2025	11	3	10	22	15	25.47	96.5	6.8726	58.0883
2025	11	3	10	32	15	25.57	96.5	6.8726	58.3179
2025	11	3	10	42	15	25.28	96.8	6.8726	57.6291
2025	11	3	10	52	15	25.16	96.4	6.8726	57.3994
2025	11	3	11	2	15	25.47	98.4	6.8787	57.9123
2025	11	3	11	12	15	26.13	95.7	6.8787	59.7508
2025	11	3	11	22	15	25.71	95.4	6.8787	58.8315
2025	11	3	11	32	15	26.67	96.5	6.8787	60.8998
2025	11	3	11	42	15	25.92	97.5	6.8787	59.0613
2025	11	3	11	52	15	25.94	97.8	6.8787	59.0612
2025	11	3	12	2	15	26.12	97.5	6.8787	59.5208
2025	11	3	12	12	15	24.7	97.2	6.8787	56.3035
2025	11	3	12	22	15	24.57	96.8	6.8787	56.0736
2025	11	3	12	32	15	24.23	95.9	6.8787	55.3842
2025	11	3	12	42	15	25.67	98.3	6.8787	58.3717
2025	11	3	12	52	15	25.59	94.7	6.8787	58.6015
2025	11	3	13	2	15	24.4	97.3	6.8787	55.6139
2025	11	3	13	12	15	25.33	95.9	6.8726	57.8583
2025	11	3	13	22	15	25.38	96.8	6.8726	57.8583
2025	11	3	13	32	15	23.86	96.7	6.8604	54.3133
2025	11	3	13	42	15	24.96	99.7	6.8665	56.4283
2025	11	3	13	52	15	24.57	94.4	6.8665	56.1989
2025	11	3	14	2	15	25.01	97.4	6.8665	56.887
2025	11	3	14	12	15	23.29	97.4	6.8665	52.9875
2025	11	3	14	22	15	26.08	94.6	6.8665	59.6396
2025	11	3	14	32	15	25.82	95.6	6.8665	58.9515
2025	11	3	14	42	15	25.42	95.6	6.8665	58.034
2025	11	3	14	52	15	24.43	95.9	6.8665	55.7401
2025	11	3	15	2	15	25.04	96	6.8604	57.0634
2025	11	3	15	12	15	26.48	96.7	6.8604	60.2717
2025	11	3	15	22	15	24.65	93.7	6.8604	56.3759
2025	11	3	15	32	15	25.01	97.4	6.8604	56.8342
2025	11	3	15	42	15	24.92	97.6	6.8604	56.6051
2025	11	3	15	52	15	24.45	96.3	6.8604	55.6884

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	3	16	2	15	24.84	96	6.8604	56.6051
2025	11	3	16	12	15	25.69	94.9	6.8604	58.6677
2025	11	3	16	22	15	24.53	95.9	6.8604	55.9177
2025	11	3	16	32	15	25.26	98.2	6.8665	57.346
2025	11	3	16	42	15	25.71	97.4	6.8726	58.5473
2025	11	3	16	52	15	26.55	99.3	6.8726	60.1545
2025	11	3	17	2	15	25.26	98.2	6.8726	57.3993
2025	11	3	17	12	15	24.94	96	6.8726	56.9401
2025	11	3	17	22	15	26.07	96.6	6.8726	59.4657
2025	11	3	17	32	15	25.16	96.4	6.8726	57.3993
2025	11	3	17	42	15	26.32	95.5	6.8726	60.1545
2025	11	3	17	52	15	25.51	97.4	6.8726	58.0881
2025	11	3	18	2	15	24.96	96.4	6.8726	56.9402
2025	11	3	18	12	15	24.96	96.4	6.8787	56.993
2025	11	3	18	22	15	25.34	96.1	6.8726	57.8586
2025	11	3	18	32	15	24.39	94.9	6.8726	55.7922
2025	11	3	18	42	15	25.33	97.7	6.8726	57.629
2025	11	3	18	52	15	25.25	99.6	6.8726	57.1698
2025	11	3	19	2	15	25.9	97.1	6.8726	59.0066
2025	11	3	19	12	15	25.78	96.7	6.8726	58.7771
2025	11	3	19	22	15	25.34	96.1	6.8726	57.8587
2025	11	3	19	32	15	26.23	97.7	6.8726	59.6955
2025	11	3	19	42	15	26.57	96.5	6.8726	60.6139
2025	11	3	19	52	15	25.64	97.8	6.8726	58.3179
2025	11	3	20	2	15	24.28	94.7	6.8726	55.5628
2025	11	3	20	12	15	25.03	97.8	6.8726	56.9404
2025	11	3	20	22	15	26.41	97.2	6.8726	60.1548
2025	11	3	20	32	15	25.9	98.7	6.8726	58.7772
2025	11	3	20	42	15	25.12	95.7	6.8726	57.3997
2025	11	3	20	52	15	26.45	96.1	6.8726	60.3845
2025	11	3	21	2	15	25.7	97.2	6.8726	58.5477
2025	11	3	21	12	15	26.39	97	6.8726	60.1549
2025	11	3	21	22	15	24.78	97	6.8726	56.4813
2025	11	3	21	32	15	25.9	97.1	6.8726	59.007
2025	11	3	21	42	15	25.12	95.7	6.8726	57.3998
2025	11	3	21	52	15	25.08	96.9	6.8726	57.1702
2025	11	3	22	2	15	26.06	96.4	6.8726	59.4662
2025	11	3	22	12	15	24.91	95.3	6.8787	56.9935
2025	11	3	22	22	15	24.47	96.8	6.8726	55.7927
2025	11	3	22	32	15	25.97	96.6	6.8726	59.2367
2025	11	3	22	42	15	26.8	97.1	6.8726	61.0735
2025	11	3	22	52	15	23.66	98.5	6.8726	53.7263
2025	11	3	23	2	15	24.33	95.9	6.8726	55.5631
2025	11	3	23	12	15	24.75	96.3	6.8726	56.4816
2025	11	3	23	22	15	25.44	93.4	6.8726	58.3184
2025	11	3	23	32	15	24.92	97.6	6.8726	56.7112
2025	11	3	23	42	15	25.83	99.1	6.8726	58.548
2025	11	3	23	52	15	26.01	97.3	6.8726	59.2368

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	4	0	2	15	24.27	98.5	6.8726	55.104
2025	11	4	0	12	15	25.02	95.5	6.8726	57.1704
2025	11	4	0	22	15	25.52	95.6	6.8726	58.3184
2025	11	4	0	32	15	24.23	95.9	6.8726	55.3336
2025	11	4	0	42	15	25.94	96	6.8726	59.2369
2025	11	4	0	52	15	24.24	96.2	6.8726	55.3337
2025	11	4	1	2	15	25.79	94.9	6.8726	59.0073
2025	11	4	1	12	15	25.63	99.2	6.8726	58.0889
2025	11	4	1	22	15	25.83	99.1	6.8726	58.5481
2025	11	4	1	32	15	24.11	97.6	6.8726	54.8745
2025	11	4	1	42	15	26.04	97.7	6.8726	59.2369
2025	11	4	1	52	15	27.19	96.8	6.8726	61.9921
2025	11	4	2	2	15	25.48	96.8	6.8726	58.0889
2025	11	4	2	12	15	24.99	94.8	6.8726	57.1705
2025	11	4	2	22	15	25.77	98.3	6.8726	58.5481
2025	11	4	2	32	15	25.75	96.2	6.8726	58.7777
2025	11	4	2	42	15	24.98	98.5	6.8726	56.7113
2025	11	4	2	52	15	25.04	96	6.8726	57.1705
2025	11	4	3	2	15	26.28	94.6	6.8726	60.1553
2025	11	4	3	12	15	25.04	96	6.8787	57.2236
2025	11	4	3	22	15	25.4	97.2	6.8726	57.8593
2025	11	4	3	32	15	25.16	98.2	6.8726	57.1705
2025	11	4	3	42	15	25.59	94.9	6.8726	58.5481
2025	11	4	3	52	15	25.22	97.5	6.8726	57.4001
2025	11	4	4	2	15	24.71	95.3	6.8787	56.5341
2025	11	4	4	12	15	25.52	95.6	6.8787	58.3726
2025	11	4	4	22	15	25.22	97.5	6.8726	57.4001
2025	11	4	4	32	15	25.12	97.5	6.8787	57.2235
2025	11	4	4	42	15	23.65	98.3	6.8787	53.7763
2025	11	4	4	52	15	24.79	97.2	6.8787	56.5341
2025	11	4	5	2	15	25.59	94.9	6.8787	58.6024
2025	11	4	5	12	15	25.02	97.6	6.8787	56.9937
2025	11	4	5	22	15	24.91	95.3	6.8787	56.9937
2025	11	4	5	32	15	25.22	97.5	6.8787	57.4533
2025	11	4	5	42	15	25	95	6.8787	57.2235
2025	11	4	5	52	15	25.27	96.6	6.8787	57.6831
2025	11	4	6	2	15	26.36	96.3	6.8787	60.2111
2025	11	4	6	12	15	24.99	97.1	6.8787	56.9937
2025	11	4	6	22	15	25.96	96.4	6.8787	59.2918
2025	11	4	6	32	15	26.21	97.2	6.8787	59.7514
2025	11	4	6	42	15	25.4	97.2	6.8787	57.9129
2025	11	4	6	52	15	25.15	96.2	6.8787	57.4533
2025	11	4	7	2	15	26.06	98.2	6.8787	59.2918
2025	11	4	7	12	15	25.22	97.5	6.8787	57.4533
2025	11	4	7	22	15	24.77	96.7	6.8787	56.534
2025	11	4	7	32	15	24.96	96.4	6.8787	56.9937
2025	11	4	7	42	15	23.8	95.3	6.8787	54.4657
2025	11	4	7	52	15	24.09	97.2	6.8787	54.9253

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	4	8	2	15	25.82	95.6	6.8787	59.062
2025	11	4	8	12	15	25.06	98.3	6.8787	56.9936
2025	11	4	8	22	15	25.93	95.8	6.8787	59.2918
2025	11	4	8	32	15	25.84	96	6.8787	59.0619
2025	11	4	8	42	15	25.66	96.5	6.8787	58.6023
2025	11	4	8	52	15	24.87	96.7	6.8848	56.8164
2025	11	4	9	2	15	25.59	94.7	6.8848	58.6566
2025	11	4	9	12	15	25.94	97.8	6.8848	59.1166
2025	11	4	9	22	15	24.42	97.8	6.8848	55.6662
2025	11	4	9	32	15	25.03	95.7	6.8848	57.2763
2025	11	4	9	42	15	25.97	94.2	6.8848	59.5765
2025	11	4	9	52	15	25	95	6.8848	57.2762
2025	11	4	10	2	15	24.14	96.2	6.8848	55.206
2025	11	4	10	12	15	24.25	96.4	6.8848	55.4359
2025	11	4	10	22	15	25.34	97.9	6.8848	57.7361
2025	11	4	10	32	15	24.14	93.3	6.8848	55.4359
2025	11	4	10	42	15	25.08	96.9	6.8848	57.276
2025	11	4	10	52	15	25.52	95.6	6.8909	58.4803
2025	11	4	11	2	15	23.92	95.8	6.8848	54.7457
2025	11	4	11	12	15	25.72	95.6	6.8909	58.9407
2025	11	4	11	22	15	25.46	98.1	6.8909	58.0197
2025	11	4	11	32	15	25.84	97.8	6.8909	58.9406
2025	11	4	11	42	15	25.22	97.5	6.8909	57.5592
2025	11	4	11	52	15	26.4	95	6.8909	60.5522
2025	11	4	12	2	15	24.47	94.5	6.8848	56.1257
2025	11	4	12	12	15	25.02	95.5	6.8848	57.2758
2025	11	4	12	22	15	24.53	95.9	6.8848	56.1256
2025	11	4	12	32	15	25.5	95	6.8848	58.4258
2025	11	4	12	42	15	25.58	96.7	6.8909	58.48
2025	11	4	12	52	15	26.21	97.2	6.8909	59.8614
2025	11	4	13	2	15	25.32	95.7	6.8848	57.9658
2025	11	4	13	12	15	24.95	96.2	6.8848	57.0457
2025	11	4	13	22	15	24.92	95.5	6.8787	56.9928
2025	11	4	13	32	15	24.2	95.2	6.8848	55.4355
2025	11	4	13	42	15	24.27	98.5	6.8848	55.2055
2025	11	4	13	52	15	24.96	93.9	6.8848	57.2757
2025	11	4	14	2	15	24.13	97.9	6.8848	54.9754
2025	11	4	14	12	15	24.22	95.7	6.8848	55.4355
2025	11	4	14	22	15	25.69	94.7	6.8848	58.8858
2025	11	4	14	32	15	23.9	95.3	6.8848	54.7454
2025	11	4	14	42	15	23.75	96.5	6.8848	54.2854
2025	11	4	14	52	15	24.45	93.5	6.8787	56.0736
2025	11	4	15	2	15	24.17	96.9	6.8787	55.1543
2025	11	4	15	12	15	24.85	93.7	6.8787	56.9928
2025	11	4	15	22	15	24.33	95.9	6.8787	55.614
2025	11	4	15	32	15	23.72	95.8	6.8787	54.2351
2025	11	4	15	42	15	24.72	95.6	6.8726	56.4808
2025	11	4	15	52	15	24.47	94.5	6.8726	56.0217

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	4	16	2	15	24.31	95.4	6.8787	55.6141
2025	11	4	16	12	15	23.82	97.7	6.8726	54.1849
2025	11	4	16	22	15	25.03	95.7	6.8726	57.1697
2025	11	4	16	32	15	24.01	97.7	6.8726	54.6442
2025	11	4	16	42	15	24.47	96.8	6.8787	55.8439
2025	11	4	16	52	15	25.49	94.7	6.8787	58.3719
2025	11	4	17	2	15	25.79	94.9	6.8787	59.0613
2025	11	4	17	12	15	26.31	97.2	6.8787	59.9805
2025	11	4	17	22	15	25.58	94.5	6.8787	58.6017
2025	11	4	17	32	15	24.33	95.9	6.8787	55.6142
2025	11	4	17	42	15	25.53	97.7	6.8787	58.1421
2025	11	4	17	52	15	24.64	97.9	6.8787	56.0738
2025	11	4	18	2	15	24.97	96.7	6.8787	56.9931
2025	11	4	18	12	15	25.44	97.9	6.8787	57.9123
2025	11	4	18	22	15	25.92	97.5	6.8787	59.0614
2025	11	4	18	32	15	24.66	96.5	6.8787	56.3037
2025	11	4	18	42	15	24.41	95.4	6.8787	55.8441
2025	11	4	18	52	15	26.17	96.6	6.8787	59.7509
2025	11	4	19	2	15	25.53	97.7	6.8787	58.1422
2025	11	4	19	12	15	26.38	98.3	6.8787	59.9807
2025	11	4	19	22	15	26.04	96	6.8787	59.5211
2025	11	4	19	32	15	26.07	96.6	6.8787	59.5211
2025	11	4	19	42	15	25.58	96.7	6.8787	58.3721
2025	11	4	19	52	15	24.91	97.4	6.8787	56.7635
2025	11	4	20	2	15	25.38	96.8	6.8787	57.9125
2025	11	4	20	12	15	26.47	96.5	6.8787	60.4405
2025	11	4	20	22	15	26.53	97.6	6.8787	60.4405
2025	11	4	20	32	15	25.64	97.8	6.8787	58.3722
2025	11	4	20	42	15	24.36	96.6	6.8726	55.5629
2025	11	4	20	52	15	25.38	96.8	6.8787	57.9127
2025	11	4	21	2	15	26.02	95.5	6.8787	59.5214
2025	11	4	21	12	15	25.27	96.6	6.8787	57.6829
2025	11	4	21	22	15	24.72	97.7	6.8787	56.304
2025	11	4	21	32	15	24.27	96.9	6.8787	55.3848
2025	11	4	21	42	15	25.3	98.9	6.8787	57.4531
2025	11	4	21	52	15	25.17	96.6	6.8787	57.4532
2025	11	4	22	2	15	26.76	96.2	6.8726	61.0735
2025	11	4	22	12	15	25.52	95.6	6.8726	58.3183
2025	11	4	22	22	15	25.22	97.5	6.8726	57.3999
2025	11	4	22	32	15	25.92	95.5	6.8787	59.2918
2025	11	4	22	42	15	25.54	96.1	6.8726	58.3184
2025	11	4	22	52	15	26.69	98.4	6.8726	60.6144
2025	11	4	23	2	15	25.99	96.9	6.8787	59.2918
2025	11	4	23	12	15	24.7	97.2	6.8726	56.252
2025	11	4	23	22	15	24.79	97.2	6.8726	56.4816
2025	11	4	23	32	15	24.16	96.7	6.8726	55.1041
2025	11	4	23	42	15	24.83	95.8	6.8726	56.7113
2025	11	4	23	52	15	26.2	95	6.8726	59.9257

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	5	0	2	15	25.76	96.5	6.8726	58.7777
2025	11	5	0	12	15	25.06	96.4	6.8726	57.1705
2025	11	5	0	22	15	25.05	96.2	6.8726	57.1705
2025	11	5	0	32	15	26.02	95.5	6.8726	59.4665
2025	11	5	0	42	15	25.06	96.4	6.8726	57.1705
2025	11	5	0	52	15	24.57	96.8	6.8726	56.0225
2025	11	5	1	2	15	25.07	96.6	6.8726	57.1705
2025	11	5	1	12	15	26.69	96.9	6.8787	60.9006
2025	11	5	1	22	15	25.5	95.2	6.8726	58.3185
2025	11	5	1	32	15	23.94	96.2	6.8726	54.6449
2025	11	5	1	42	15	26.72	98.8	6.8726	60.6146
2025	11	5	1	52	15	25.79	96.9	6.8787	58.8323
2025	11	5	2	2	15	26.14	95.9	6.8787	59.7516
2025	11	5	2	12	15	26.62	95.4	6.8726	60.8442
2025	11	5	2	22	15	25	95	6.8787	57.2236
2025	11	5	2	32	15	24.41	97.5	6.8787	55.6149
2025	11	5	2	42	15	26.01	97.3	6.8787	59.2919
2025	11	5	2	52	15	25.45	96.3	6.8726	58.0889
2025	11	5	3	2	15	24.49	94.9	6.8787	56.0745
2025	11	5	3	12	15	24.73	95.8	6.8726	56.4817
2025	11	5	3	22	15	25.23	95.9	6.8726	57.6297
2025	11	5	3	32	15	25.54	97.9	6.8726	58.0889
2025	11	5	3	42	15	24.3	95.2	6.8787	55.6149
2025	11	5	3	52	15	24.98	98.5	6.8787	56.7639
2025	11	5	4	2	15	25.13	97.8	6.8787	57.2235
2025	11	5	4	12	15	25.75	96.2	6.8787	58.8322
2025	11	5	4	22	15	24.41	95.4	6.8787	55.8446
2025	11	5	4	32	15	25.45	96.3	6.8787	58.1428
2025	11	5	4	42	15	25.32	97.5	6.8787	57.6831
2025	11	5	4	52	15	24.71	95.3	6.8787	56.5341
2025	11	5	5	2	15	24.23	95.9	6.8787	55.385
2025	11	5	5	12	15	25.29	94.8	6.8787	57.9129
2025	11	5	5	22	15	26.05	97.9	6.8787	59.2918
2025	11	5	5	32	15	25.42	97.5	6.8787	57.9129
2025	11	5	5	42	15	24.77	96.7	6.8787	56.534
2025	11	5	5	52	15	26.01	97.3	6.8787	59.2917
2025	11	5	6	2	15	24.78	97	6.8787	56.534
2025	11	5	6	12	15	24.97	96.7	6.8787	56.9936
2025	11	5	6	22	15	25.17	96.6	6.8787	57.4532
2025	11	5	6	32	15	25.71	97.4	6.8787	58.6023
2025	11	5	6	42	15	25.55	98.1	6.8787	58.1426
2025	11	5	6	52	15	25.51	95.4	6.8787	58.3724
2025	11	5	7	2	15	25.39	94.7	6.8787	58.1426
2025	11	5	7	12	15	25.02	95.5	6.8787	57.2234
2025	11	5	7	22	15	24.91	95.3	6.8787	56.9935
2025	11	5	7	32	15	26.28	94.6	6.8787	60.2109
2025	11	5	7	42	15	24.37	96.8	6.8787	55.6147
2025	11	5	7	52	15	24.78	97	6.8787	56.5339

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	5	8	2	15	25.03	97.8	6.8787	56.9935
2025	11	5	8	12	15	24.27	96.9	6.8787	55.3848
2025	11	5	8	22	15	24.95	98.1	6.8787	56.7637
2025	11	5	8	32	15	25.22	95.7	6.8787	57.6829
2025	11	5	8	42	15	25.44	97.9	6.8787	57.9127
2025	11	5	8	52	15	25.52	95.6	6.8787	58.3723
2025	11	5	9	2	15	25.51	95.4	6.8848	58.4264
2025	11	5	9	12	15	26.56	98	6.8848	60.4966
2025	11	5	9	22	15	26.23	97.7	6.8848	59.8065
2025	11	5	9	32	15	25.27	96.6	6.8848	57.7362
2025	11	5	9	42	15	27.25	97.8	6.8848	62.1066
2025	11	5	9	52	15	25.83	99.1	6.8848	58.6562
2025	11	5	10	2	15	24.91	97.4	6.8848	56.816
2025	11	5	10	12	15	25.87	98.2	6.8848	58.8862
2025	11	5	10	22	15	24.99	97.1	6.8848	57.046
2025	11	5	10	32	15	25.02	97.6	6.8848	57.046
2025	11	5	10	42	15	25.69	94.9	6.8848	58.8861
2025	11	5	10	52	15	26.56	96.3	6.8848	60.7263
2025	11	5	11	2	15	24.78	94.6	6.8787	56.7632
2025	11	5	11	12	15	24.46	94	6.8787	56.0737
2025	11	5	11	22	15	24.17	94.5	6.8787	55.3842
2025	11	5	11	32	15	24.33	92.8	6.8726	55.792
2025	11	5	11	42	15	24.89	94.8	6.8787	56.9929
2025	11	5	11	52	15	24.54	96.1	6.8726	56.0215
2025	11	5	12	2	15	25.77	94.2	6.8787	59.0612
2025	11	5	12	12	15	24.03	96	6.8787	54.9246
2025	11	5	12	22	15	24.54	96.1	6.8787	56.0736
2025	11	5	12	32	15	25.43	97.7	6.8726	57.8583
2025	11	5	12	42	15	25.39	97	6.8665	57.8046
2025	11	5	12	52	15	24.45	96.3	6.8726	55.7919
2025	11	5	13	2	15	24.11	95.5	6.8726	55.1031
2025	11	5	13	12	15	24.47	94.2	6.8787	56.0735
2025	11	5	13	22	15	24.14	96.2	6.8726	55.1031
2025	11	5	13	32	15	24.6	97.2	6.8787	56.0735
2025	11	5	13	42	15	25.03	95.7	6.8787	57.2225
2025	11	5	13	52	15	24.06	94.1	6.8726	55.1031
2025	11	5	14	2	15	23.83	96	6.8665	54.3638
2025	11	5	14	12	15	23.82	97.7	6.8665	54.1344
2025	11	5	14	22	15	23.99	97.2	6.8726	54.6439
2025	11	5	14	32	15	24.25	96.4	6.8726	55.3327
2025	11	5	14	42	15	24.68	97	6.8726	56.2511
2025	11	5	14	52	15	24.65	96.3	6.8665	56.1988
2025	11	5	15	2	15	24.87	94.4	6.8726	56.9399
2025	11	5	15	12	15	24.68	97	6.8665	56.1989
2025	11	5	15	22	15	25.76	93.8	6.8726	59.0063
2025	11	5	15	32	15	24.92	95.5	6.8665	56.8871
2025	11	5	15	42	15	23.82	97.7	6.8726	54.1848
2025	11	5	15	52	15	24.33	95.9	6.8726	55.5624

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	5	16	2	15	24.06	94.1	6.8665	55.052
2025	11	5	16	12	15	23.49	95.1	6.8665	53.6757
2025	11	5	16	22	15	25.57	98.3	6.8665	58.034
2025	11	5	16	32	15	23.77	94.3	6.8604	54.3134
2025	11	5	16	42	15	24.98	96.9	6.8604	56.8343
2025	11	5	16	52	15	24.6	95.1	6.8665	56.199
2025	11	5	17	2	15	23.95	96.5	6.8604	54.5425
2025	11	5	17	12	15	24.5	95.2	6.8604	55.9176
2025	11	5	17	22	15	23.69	95.1	6.8665	54.1345
2025	11	5	17	32	15	24.86	93.9	6.8604	56.8343
2025	11	5	17	42	15	24.63	95.8	6.8665	56.199
2025	11	5	17	52	15	26.28	98.3	6.8665	59.6398
2025	11	5	18	2	15	24.87	94.4	6.8543	56.7814
2025	11	5	18	12	15	24.05	93.6	6.8604	55.0009
2025	11	5	18	22	15	24.91	95.3	6.8543	56.7815
2025	11	5	18	32	15	24.27	94.3	6.8543	55.4077
2025	11	5	18	42	15	23.84	93.4	6.8543	54.4919
2025	11	5	18	52	15	24.64	96.1	6.8543	56.0946
2025	11	5	19	2	15	24.98	96.9	6.8543	56.7815
2025	11	5	19	12	15	24.49	94.9	6.8543	55.8657
2025	11	5	19	22	15	23.98	94.5	6.8543	54.7209
2025	11	5	19	32	15	23.64	96.3	6.8543	53.8051
2025	11	5	19	42	15	24.17	94.5	6.8543	55.1788
2025	11	5	19	52	15	24.1	97.4	6.8543	54.7209
2025	11	5	20	2	15	23.56	94.1	6.8604	53.8552
2025	11	5	20	12	15	24.75	93.5	6.8604	56.6053
2025	11	5	20	22	15	24.36	94	6.8665	55.7404
2025	11	5	20	32	15	24.1	97.4	6.8665	54.8229
2025	11	5	20	42	15	24.92	95.5	6.8665	56.8873
2025	11	5	20	52	15	24.48	97	6.8604	55.6886
2025	11	5	21	2	15	25.84	96	6.8604	58.897
2025	11	5	21	12	15	24.6	97.2	6.8543	55.8658
2025	11	5	21	22	15	26.25	96.1	6.8604	59.8137
2025	11	5	21	32	15	23.9	97.5	6.8665	54.3642
2025	11	5	21	42	15	25.63	95.8	6.8604	58.4387
2025	11	5	21	52	15	24.84	96	6.8604	56.6054
2025	11	5	22	2	15	25.33	97.7	6.8604	57.5221
2025	11	5	22	12	15	24.86	96.5	6.8604	56.6054
2025	11	5	22	22	15	24.17	94.5	6.8604	55.2304
2025	11	5	22	32	15	24.81	95.3	6.8604	56.6054
2025	11	5	22	42	15	24.03	96	6.8604	54.7721
2025	11	5	22	52	15	25.51	95.4	6.8604	58.2096
2025	11	5	23	2	15	24.7	95.1	6.8604	56.3763
2025	11	5	23	12	15	23.93	96	6.8604	54.5429
2025	11	5	23	22	15	25.39	94.7	6.8726	58.0884
2025	11	5	23	32	15	25.09	94.8	6.8726	57.3996
2025	11	5	23	42	15	24.64	96.1	6.8787	56.3038
2025	11	5	23	52	15	22.52	95.9	6.8726	51.43

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	6	0	2	15	24.57	94.2	6.8787	56.3038
2025	11	6	0	12	15	24.85	98.1	6.8726	56.4812
2025	11	6	0	22	15	24.69	94.9	6.8787	56.5337
2025	11	6	0	32	15	24.82	97.6	6.8787	56.5337
2025	11	6	0	42	15	24.22	95.7	6.8787	55.3846
2025	11	6	0	52	15	25.34	96.1	6.8787	57.9125
2025	11	6	1	2	15	25.07	96.6	6.8787	57.2231
2025	11	6	1	12	15	24.77	94.4	6.8787	56.7635
2025	11	6	1	22	15	24.11	95.5	6.8787	55.1548
2025	11	6	1	32	15	24.92	97.6	6.8787	56.7635
2025	11	6	1	42	15	23.93	96	6.8787	54.6952
2025	11	6	1	52	15	25.47	96.5	6.8848	58.1963
2025	11	6	2	2	15	25.31	95.4	6.8848	57.9663
2025	11	6	2	12	15	23.9	95.3	6.8848	54.7459
2025	11	6	2	22	15	24.78	97	6.8848	56.5861
2025	11	6	2	32	15	24.78	97	6.8848	56.5861
2025	11	6	2	42	15	24.04	98.1	6.8848	54.7459
2025	11	6	2	52	15	24.86	96.5	6.8848	56.8161
2025	11	6	3	2	15	24.83	95.8	6.8848	56.8161
2025	11	6	3	12	15	25.75	96.2	6.8848	58.8864
2025	11	6	3	22	15	25.46	93.8	6.8848	58.4263
2025	11	6	3	32	15	24.64	96.1	6.8909	56.4083
2025	11	6	3	42	15	25.42	95.6	6.8909	58.2502
2025	11	6	3	52	15	25.62	95.6	6.8909	58.7107
2025	11	6	4	2	15	24.19	95	6.8909	55.4873
2025	11	6	4	12	15	24.66	96.5	6.8909	56.4083
2025	11	6	4	22	15	24.23	95.9	6.8909	55.4873
2025	11	6	4	32	15	23.56	94.1	6.8909	54.1059
2025	11	6	4	42	15	25.51	97.4	6.8909	58.2502
2025	11	6	4	52	15	24.09	97.2	6.8909	55.0269
2025	11	6	5	2	15	25.45	96.3	6.8909	58.2502
2025	11	6	5	12	15	26.39	97	6.8909	60.3223
2025	11	6	5	22	15	23.7	97.5	6.8909	54.1059
2025	11	6	5	32	15	24.17	96.9	6.897	55.3083
2025	11	6	5	42	15	25.62	95.6	6.8909	58.7107
2025	11	6	5	52	15	26.55	96.1	6.8909	60.7828
2025	11	6	6	2	15	24.16	96.7	6.897	55.3083
2025	11	6	6	12	15	24.22	95.7	6.897	55.5387
2025	11	6	6	22	15	24.16	96.7	6.897	55.3083
2025	11	6	6	32	15	24.87	96.7	6.897	56.9214
2025	11	6	6	42	15	24.83	95.8	6.897	56.9214
2025	11	6	6	52	15	25.52	95.6	6.897	58.5346
2025	11	6	7	2	15	23.99	95	6.897	55.0778
2025	11	6	7	12	15	24	97.4	6.897	54.8474
2025	11	6	7	22	15	24.82	95.5	6.897	56.9214
2025	11	6	7	32	15	26.21	97.2	6.897	59.9173
2025	11	6	7	42	15	24.61	97.5	6.897	56.2301
2025	11	6	7	52	15	24.52	95.6	6.9031	56.2821

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	6	8	2	15	24.82	97.6	6.9031	56.7434
2025	11	6	8	12	15	24.99	97.1	6.9031	57.2048
2025	11	6	8	22	15	25.98	94.6	6.9031	59.742
2025	11	6	8	32	15	23.78	97	6.9031	54.4368
2025	11	6	8	42	15	25.07	96.6	6.9031	57.4354
2025	11	6	8	52	15	24.48	97	6.9031	56.0514
2025	11	6	9	2	15	24.83	95.8	6.9031	56.974
2025	11	6	9	12	15	26.28	96.8	6.9031	60.2033
2025	11	6	9	22	15	24.53	95.9	6.9031	56.282
2025	11	6	9	32	15	25.3	95.2	6.9092	58.181
2025	11	6	9	42	15	24.58	97	6.9092	56.3339
2025	11	6	9	52	15	25.43	95.9	6.9092	58.4118
2025	11	6	10	2	15	25.08	96.9	6.9092	57.4882
2025	11	6	10	12	15	24.9	95.1	6.9092	57.2573
2025	11	6	10	22	15	24.13	95.9	6.9092	55.4103
2025	11	6	10	32	15	23.9	95.3	6.9153	54.9992
2025	11	6	10	42	15	24.19	97.1	6.9153	55.4614
2025	11	6	10	52	15	25.33	97.7	6.9153	58.0033
2025	11	6	11	2	15	25.37	94.3	6.9153	58.4655
2025	11	6	11	12	15	24.72	97.7	6.9153	56.6167
2025	11	6	11	22	15	25.74	96	6.9153	59.1587
2025	11	6	11	32	15	23.64	93.2	6.9153	54.5369
2025	11	6	11	42	15	25.43	92.7	6.9153	58.6965
2025	11	6	11	52	15	24.83	95.8	6.9153	57.0788
2025	11	6	12	2	15	23.86	98.4	6.9153	54.5368
2025	11	6	12	12	15	23.33	96.2	6.9153	53.6125
2025	11	6	12	22	15	23.86	94.1	6.9214	55.0497
2025	11	6	12	32	15	24.15	93.8	6.9214	55.7436
2025	11	6	12	42	15	25.38	96.8	6.9153	58.2342
2025	11	6	12	52	15	25.07	94.3	6.9214	57.8253
2025	11	6	13	2	15	24.88	96.9	6.9214	57.1313
2025	11	6	13	12	15	24.79	94.9	6.9214	57.1313
2025	11	6	13	22	15	25.65	98.1	6.9214	58.7504
2025	11	6	13	32	15	24.51	95.4	6.9214	56.4374
2025	11	6	13	42	15	25.38	96.8	6.9214	58.2878
2025	11	6	13	52	15	24.35	93.8	6.9214	56.2061
2025	11	6	14	2	15	24.96	94.1	6.9214	57.5939
2025	11	6	14	12	15	25.44	96.1	6.9214	58.5191
2025	11	6	14	22	15	24.74	96	6.9214	56.9
2025	11	6	14	32	15	24.3	97.3	6.9214	55.7435
2025	11	6	14	42	15	25.49	94.7	6.9214	58.7504
2025	11	6	14	52	15	24.39	97.1	6.9214	55.9748
2025	11	6	15	2	15	24.77	94.2	6.9214	57.1313
2025	11	6	15	12	15	24.86	96.5	6.9214	57.1313
2025	11	6	15	22	15	25.56	94	6.9214	58.9817
2025	11	6	15	32	15	24.74	96	6.9214	56.9
2025	11	6	15	42	15	24.3	97.3	6.9214	55.7435
2025	11	6	15	52	15	25.62	95.6	6.9214	58.9818

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	6	16	2	15	25.52	95.6	6.9214	58.7505
2025	11	6	16	12	15	24.56	96.5	6.9214	56.4375
2025	11	6	16	22	15	25.33	95.9	6.9214	58.2879
2025	11	6	16	32	15	23.3	95.4	6.9214	53.6619
2025	11	6	16	42	15	25.06	94.1	6.9214	57.8253
2025	11	6	16	52	15	24.72	97.7	6.9214	56.6688
2025	11	6	17	2	15	24.78	97	6.9214	56.9001
2025	11	6	17	12	15	24.7	95.1	6.9275	56.9526
2025	11	6	17	22	15	24.74	96	6.9275	56.9526
2025	11	6	17	32	15	24.39	97.1	6.9214	55.9749
2025	11	6	17	42	15	25.53	97.7	6.9214	58.5192
2025	11	6	17	52	15	24.89	97.2	6.9275	57.1841
2025	11	6	18	2	15	25.24	96.1	6.9275	58.1102
2025	11	6	18	12	15	25.5	97.2	6.9275	58.5732
2025	11	6	18	22	15	24.58	94.7	6.9336	56.7733
2025	11	6	18	32	15	24.95	93.7	6.9397	57.7534
2025	11	6	18	42	15	23.55	93.9	6.9397	54.5062
2025	11	6	18	52	15	25.35	93.6	6.9397	58.6812
2025	11	6	19	2	15	24.23	97.8	6.9458	55.7171
2025	11	6	19	12	15	24.64	96.1	6.9458	56.8779
2025	11	6	19	22	15	25.37	94.3	6.9458	58.7352
2025	11	6	19	32	15	25.06	96.4	6.9458	57.8066
2025	11	6	19	42	15	24.73	95.8	6.9519	57.1626
2025	11	6	19	52	15	26.33	95.7	6.9519	60.8805
2025	11	6	20	2	15	25.63	95.8	6.9519	59.2539
2025	11	6	20	12	15	25.27	96.6	6.9519	58.3245
2025	11	6	20	22	15	25.63	95.8	6.9519	59.254
2025	11	6	20	32	15	25.71	97.4	6.9519	59.254
2025	11	6	20	42	15	25.78	98.5	6.9519	59.254
2025	11	6	20	52	15	25.51	95.4	6.9519	59.0217
2025	11	6	21	2	15	25.6	97.2	6.9519	59.0217
2025	11	6	21	12	15	25.72	95.6	6.9519	59.4864
2025	11	6	21	22	15	24.88	96.9	6.9519	57.3951
2025	11	6	21	32	15	25.32	95.7	6.9519	58.557
2025	11	6	21	42	15	26.18	96.8	6.958	60.4714
2025	11	6	21	52	15	27.1	97	6.9519	62.5073
2025	11	6	22	2	15	24.96	96.4	6.958	57.6805
2025	11	6	22	12	15	24.47	94.5	6.958	56.7502
2025	11	6	22	22	15	25.23	97.7	6.958	58.1457
2025	11	6	22	32	15	26.15	96.1	6.958	60.4715
2025	11	6	22	42	15	25.72	95.6	6.958	59.5412
2025	11	6	22	52	15	24.27	96.9	6.958	56.0525
2025	11	6	23	2	15	25.42	95.6	6.958	58.8435
2025	11	6	23	12	15	24.5	95.2	6.958	56.7503
2025	11	6	23	22	15	25.96	93.8	6.958	60.239
2025	11	6	23	32	15	25.22	95.7	6.958	58.3784
2025	11	6	23	42	15	25.86	96.4	6.958	59.7739
2025	11	6	23	52	15	26.29	94.8	6.958	60.9368

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	7	0	2	15	24.69	94.9	6.958	57.2155
2025	11	7	0	12	15	26.31	95.2	6.958	60.9369
2025	11	7	0	22	15	25.36	94.1	6.958	58.8436
2025	11	7	0	32	15	24.57	96.8	6.958	56.7504
2025	11	7	0	42	15	23.85	93.8	6.958	55.3549
2025	11	7	0	52	15	24.85	98.1	6.958	57.2156
2025	11	7	1	2	15	25.37	96.6	6.958	58.6111
2025	11	7	1	12	15	26.48	94.5	6.958	61.4021
2025	11	7	1	22	15	25.12	95.7	6.958	58.1459
2025	11	7	1	32	15	26.31	97.2	6.9641	60.76
2025	11	7	1	42	15	26.61	97.1	6.958	61.4021
2025	11	7	1	52	15	24.67	96.8	6.958	56.983
2025	11	7	2	2	15	24.83	95.8	6.958	57.4482
2025	11	7	2	12	15	25.37	96.6	6.9641	58.6649
2025	11	7	2	22	15	24.99	94.8	6.9641	57.9665
2025	11	7	2	32	15	25.27	96.6	6.9641	58.4321
2025	11	7	2	42	15	25	95	6.9641	57.9665
2025	11	7	2	52	15	26.11	95.3	6.9641	60.5272
2025	11	7	3	2	15	24.41	95.4	6.9641	56.5697
2025	11	7	3	12	15	26.16	96.4	6.9641	60.5272
2025	11	7	3	22	15	24.87	96.7	6.9641	57.5009
2025	11	7	3	32	15	25.55	98.1	6.9641	58.8977
2025	11	7	3	42	15	25.65	96.3	6.9641	59.3633
2025	11	7	3	52	15	24.02	95.7	6.9641	55.6385
2025	11	7	4	2	15	25.7	95.1	6.9641	59.5961
2025	11	7	4	12	15	25.99	96.9	6.9641	60.0617
2025	11	7	4	22	15	25.55	93.6	6.9641	59.3633
2025	11	7	4	32	15	25.73	95.8	6.9702	59.6507
2025	11	7	4	42	15	25.22	95.7	6.9641	58.4321
2025	11	7	4	52	15	25.27	96.6	6.9641	58.4321
2025	11	7	5	2	15	25.32	95.7	6.9702	58.7186
2025	11	7	5	12	15	25.26	96.4	6.9641	58.4321
2025	11	7	5	22	15	25.31	95.4	6.9702	58.7186
2025	11	7	5	32	15	25.17	96.6	6.9702	58.2526
2025	11	7	5	42	15	26.07	94.2	6.9702	60.5827
2025	11	7	5	52	15	26.2	97	6.9702	60.5827
2025	11	7	6	2	15	25.19	94.8	6.9702	58.4856
2025	11	7	6	12	15	25.84	96	6.9702	59.8837
2025	11	7	6	22	15	25.43	95.9	6.9702	58.9516
2025	11	7	6	32	15	24.99	94.8	6.9702	58.0196
2025	11	7	6	42	15	25.55	99.5	6.9702	58.7186
2025	11	7	6	52	15	26.35	97.9	6.9763	60.8714
2025	11	7	7	2	15	26.07	96.6	6.9763	60.4049
2025	11	7	7	12	15	26.17	96.6	6.9763	60.6381
2025	11	7	7	22	15	24.61	97.5	6.9763	56.9065
2025	11	7	7	32	15	26.31	97.2	6.9763	60.8713
2025	11	7	7	42	15	26.45	93.5	6.9763	61.571
2025	11	7	7	52	15	25.29	97	6.9763	58.5391

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	7	8	2	15	26.2	97	6.9763	60.6381
2025	11	7	8	12	15	25.68	96.7	6.9824	59.5264
2025	11	7	8	22	15	26.21	97.2	6.9763	60.6381
2025	11	7	8	32	15	25.43	95.9	6.9824	59.0595
2025	11	7	8	42	15	26.46	96.3	6.9824	61.3939
2025	11	7	8	52	15	26.02	97.5	6.9824	60.2266
2025	11	7	9	2	15	25.69	94.7	6.9824	59.7597
2025	11	7	9	12	15	26.62	97.3	6.9824	61.6272
2025	11	7	9	22	15	23.69	97.3	6.9885	54.9076
2025	11	7	9	32	15	24.79	94.9	6.9885	57.7114
2025	11	7	9	42	15	25.28	96.8	6.9885	58.6459
2025	11	7	9	52	15	25.07	96.6	6.9885	58.1786
2025	11	7	10	2	15	25.66	96.5	6.9885	59.5805
2025	11	7	10	12	15	26.18	96.8	6.9885	60.7487
2025	11	7	10	22	15	25.64	97.8	6.9885	59.3468
2025	11	7	10	32	15	26.23	97.7	6.9885	60.7486
2025	11	7	10	42	15	24.77	94.2	6.9945	57.7638
2025	11	7	10	52	15	24.76	93.9	6.9945	57.7638
2025	11	7	11	2	15	25.77	94.2	6.9945	60.1024
2025	11	7	11	12	15	25.93	95.8	7.0006	60.3913
2025	11	7	11	22	15	26.37	96.5	7.0006	61.3275
2025	11	7	11	32	15	26.02	97.5	7.0006	60.3912
2025	11	7	11	42	15	25.57	96.5	7.0067	59.5091
2025	11	7	11	52	15	26.48	94.5	7.0006	61.7956
2025	11	7	12	2	15	26.32	95.5	7.0067	61.3833
2025	11	7	12	12	15	25.93	95.8	7.0128	60.5012
2025	11	7	12	22	15	26.29	94.8	7.0067	61.3833
2025	11	7	12	32	15	26.19	94.8	7.0128	61.2047
2025	11	7	12	42	15	24.33	95.9	7.0128	56.7491
2025	11	7	12	52	15	26.12	97.5	7.0189	60.7909
2025	11	7	13	2	15	25.63	97.6	7.0189	59.6173
2025	11	7	13	12	15	25.27	96.6	7.0189	58.9131
2025	11	7	13	22	15	26.18	96.8	7.0189	61.0256
2025	11	7	13	32	15	25.5	95	7.025	59.6714
2025	11	7	13	42	15	25.79	94.7	7.025	60.3762
2025	11	7	13	52	15	25.49	94.7	7.025	59.6714
2025	11	7	14	2	15	26.1	97	7.025	60.8461
2025	11	7	14	12	15	25.79	94.9	7.025	60.3762
2025	11	7	14	22	15	25.8	95.1	7.025	60.3762
2025	11	7	14	32	15	26.04	96	7.025	60.8461
2025	11	7	14	42	15	25.49	94.7	7.025	59.6715
2025	11	7	14	52	15	25.78	94.4	7.025	60.3763
2025	11	7	15	2	15	25.03	93	7.025	58.7318
2025	11	7	15	12	15	25.92	95.5	7.025	60.6112
2025	11	7	15	22	15	24.99	94.8	7.025	58.4969
2025	11	7	15	32	15	24.68	97	7.025	57.5572
2025	11	7	15	42	15	24.47	94.2	7.025	57.3223
2025	11	7	15	52	15	26.38	94.6	7.025	61.7859

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	7	16	2	15	25.4	95.2	7.025	59.4367
2025	11	7	16	12	15	25.78	96.7	7.0311	60.1961
2025	11	7	16	22	15	25.93	95.8	7.0311	60.6664
2025	11	7	16	32	15	25.19	97.1	7.0311	58.7853
2025	11	7	16	42	15	26.04	96	7.025	60.8463
2025	11	7	16	52	15	26.01	95.3	7.0311	60.9015
2025	11	7	17	2	15	23.68	94.6	7.0311	55.4933
2025	11	7	17	12	15	24.58	97	7.0372	57.4265
2025	11	7	17	22	15	24.63	92.8	7.0311	57.8447
2025	11	7	17	32	15	24.36	94	7.0372	57.1911
2025	11	7	17	42	15	23.76	94.1	7.0372	55.779
2025	11	7	17	52	15	24.31	95.4	7.0311	56.9042
2025	11	7	18	2	15	24.81	95.3	7.0372	58.1326
2025	11	7	18	12	15	25.63	97.6	7.0372	59.7801
2025	11	7	18	22	15	25.4	95.2	7.0372	59.5447
2025	11	7	18	32	15	24.73	97.9	7.0372	57.6619
2025	11	7	18	42	15	25.63	95.8	7.0372	60.0155
2025	11	7	18	52	15	25.78	98.5	7.0372	60.0155
2025	11	7	19	2	15	25.38	96.8	7.0372	59.3095
2025	11	7	19	12	15	25.15	93.6	7.0372	59.0741
2025	11	7	19	22	15	24.7	95.1	7.0372	57.8974
2025	11	7	19	32	15	25.63	97.6	7.0372	59.7802
2025	11	7	19	42	15	25.4	95.2	7.0372	59.5449
2025	11	7	19	52	15	25.82	95.6	7.0372	60.4863
2025	11	7	20	2	15	25.32	95.7	7.0372	59.3096
2025	11	7	20	12	15	25.3	95	7.0372	59.3096
2025	11	7	20	22	15	25.29	94.8	7.0372	59.3096
2025	11	7	20	32	15	24.61	97.5	7.0372	57.4268
2025	11	7	20	42	15	24.38	94.7	7.0372	57.1915
2025	11	7	20	52	15	24.14	93.3	7.0372	56.7208
2025	11	7	21	2	15	24.43	95.9	7.0372	57.1915
2025	11	7	21	12	15	26.11	95.3	7.0372	61.1926
2025	11	7	21	22	15	26.06	96.4	7.0372	60.9572
2025	11	7	21	32	15	25	95	7.0372	58.6037
2025	11	7	21	42	15	24.38	94.7	7.0372	57.1916
2025	11	7	21	52	15	24.86	98.3	7.0372	57.8976
2025	11	7	22	2	15	25.59	94.9	7.0372	60.0159
2025	11	7	22	12	15	26.51	95.2	7.0372	62.1341
2025	11	7	22	22	15	25.85	93.5	7.0433	60.777
2025	11	7	22	32	15	24.58	94.7	7.0433	57.7146
2025	11	7	22	42	15	26.06	96.4	7.0372	60.9574
2025	11	7	22	52	15	26.11	97.3	7.0372	60.9574
2025	11	7	23	2	15	26.07	96.6	7.0372	60.9574
2025	11	7	23	12	15	26.58	96.7	7.0433	62.1905
2025	11	7	23	22	15	25.7	97.2	7.0433	60.0704
2025	11	7	23	32	15	25.91	97.3	7.0433	60.5416
2025	11	7	23	42	15	26.56	96.3	7.0433	62.1906
2025	11	7	23	52	15	25.82	97.6	7.0433	60.306

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	8	0	2	15	26.8	94.9	7.0433	62.8973
2025	11	8	0	12	15	25.7	95.1	7.0433	60.306
2025	11	8	0	22	15	25.1	95	7.0433	58.8926
2025	11	8	0	32	15	25.92	95.5	7.0433	60.7772
2025	11	8	0	42	15	24.46	94	7.0433	57.4792
2025	11	8	0	52	15	26.5	98.7	7.0433	61.7195
2025	11	8	1	2	15	26.99	96.8	7.0433	63.1329
2025	11	8	1	12	15	26.8	94.9	7.0433	62.8973
2025	11	8	1	22	15	26.12	95.5	7.0433	61.2483
2025	11	8	1	32	15	24.7	95.1	7.0433	57.9504
2025	11	8	1	42	15	26.27	94.1	7.0433	61.7195
2025	11	8	1	52	15	24.87	94.2	7.0433	58.4215
2025	11	8	2	2	15	25.05	93.7	7.0494	58.946
2025	11	8	2	12	15	25.29	97	7.0494	59.1817
2025	11	8	2	22	15	25.93	92.9	7.0433	61.0128
2025	11	8	2	32	15	26.2	95	7.0494	61.5396
2025	11	8	2	42	15	24.96	93.9	7.0494	58.7102
2025	11	8	2	52	15	25.49	94.7	7.0494	59.8891
2025	11	8	3	2	15	26.77	94.1	7.0494	62.9543
2025	11	8	3	12	15	25.99	96.9	7.0494	60.8322
2025	11	8	3	22	15	25.76	96.5	7.0494	60.3606
2025	11	8	3	32	15	25.77	94.2	7.0555	60.6512
2025	11	8	3	42	15	26.53	95.6	7.0555	62.3032
2025	11	8	3	52	15	26.86	96.2	7.0555	63.0112
2025	11	8	4	2	15	25.37	96.6	7.0555	59.4712
2025	11	8	4	12	15	26.57	98.2	7.0616	62.1233
2025	11	8	4	22	15	25.3	95	7.0616	59.525
2025	11	8	4	32	15	25.81	95.3	7.0616	60.706
2025	11	8	4	42	15	26.78	94.5	7.0677	63.1251
2025	11	8	4	52	15	26.16	98.1	7.0677	61.2337
2025	11	8	5	2	15	25.29	94.8	7.0738	59.6325
2025	11	8	5	12	15	26.34	95.9	7.0738	61.9988
2025	11	8	5	22	15	26.14	95.9	7.0738	61.5256
2025	11	8	5	32	15	24.16	94	7.0738	57.0295
2025	11	8	5	42	15	25.34	96.1	7.0799	59.6862
2025	11	8	5	52	15	25.11	95.3	7.0738	59.1592
2025	11	8	6	2	15	26.64	95.8	7.0799	62.7652
2025	11	8	6	12	15	25.17	96.6	7.0799	59.2125
2025	11	8	6	22	15	26.46	96.3	7.0799	62.2915
2025	11	8	6	32	15	25.38	94.5	7.0799	59.923
2025	11	8	6	42	15	25.85	93.5	7.086	61.1623
2025	11	8	6	52	15	26.03	95.7	7.0799	61.3441
2025	11	8	7	2	15	25.87	96.7	7.086	60.9252
2025	11	8	7	12	15	26.48	94.5	7.086	62.5847
2025	11	8	7	22	15	26.06	93.7	7.086	61.6364
2025	11	8	7	32	15	24.96	96.4	7.086	58.7917
2025	11	8	7	42	15	24.43	92.8	7.086	57.8434
2025	11	8	7	52	15	26.33	92.8	7.086	62.3476

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	8	8	2	15	25.79	94.7	7.0921	60.98
2025	11	8	8	12	15	24.08	94.8	7.0921	56.9463
2025	11	8	8	22	15	25.56	94	7.0921	60.5055
2025	11	8	8	32	15	26.45	93.5	7.0921	62.6409
2025	11	8	8	42	15	25.11	95.3	7.0921	59.3191
2025	11	8	8	52	15	24.94	96	7.0921	58.8445
2025	11	8	9	2	15	26.87	94.1	7.0921	63.59
2025	11	8	9	12	15	24.86	93.9	7.0982	58.8973
2025	11	8	9	22	15	24.45	93.8	7.0982	57.9473
2025	11	8	9	32	15	25.73	95.8	7.0982	60.7972
2025	11	8	9	42	15	25.13	92.7	7.0982	59.6097
2025	11	8	9	52	15	24.62	92.6	7.1043	58.4747
2025	11	8	10	2	15	23.64	93.2	7.1043	56.0976
2025	11	8	10	12	15	25.72	95.6	7.1043	60.8517
2025	11	8	10	22	15	24.59	94.9	7.1043	58.2369
2025	11	8	10	32	15	25.75	96.2	7.1043	60.8516
2025	11	8	10	42	15	25.25	93.6	7.1043	59.9008
2025	11	8	10	52	15	25.63	92.7	7.1043	60.8515
2025	11	8	11	2	15	25.48	96.8	7.1043	60.1384
2025	11	8	11	12	15	25.36	93.8	7.1104	60.1923
2025	11	8	11	22	15	25.36	94.1	7.1104	60.1923
2025	11	8	11	32	15	26.56	93.9	7.1104	63.0473
2025	11	8	11	42	15	24.13	92.9	7.1104	57.3373
2025	11	8	11	52	15	26.08	94.4	7.1104	61.8577
2025	11	8	12	2	15	25.26	94.1	7.1104	59.9543
2025	11	8	12	12	15	24.92	95.5	7.1104	59.0027
2025	11	8	12	22	15	23.66	94.1	7.1104	56.1477
2025	11	8	12	32	15	25.65	93.6	7.1104	60.9059
2025	11	8	12	42	15	25.13	95.9	7.1104	59.4784
2025	11	8	12	52	15	25.83	92.9	7.1165	61.4368
2025	11	8	13	2	15	24.43	92.8	7.1104	58.0509
2025	11	8	13	12	15	25.46	93.8	7.1165	60.4842
2025	11	8	13	22	15	25.5	95	7.1165	60.4842
2025	11	8	13	32	15	24.25	93.5	7.1165	57.6267
2025	11	8	13	42	15	25.59	94.7	7.1165	60.7224
2025	11	8	13	52	15	26.32	95.5	7.1165	62.3892
2025	11	8	14	2	15	26.04	93.3	7.1165	61.913
2025	11	8	14	12	15	25.3	95.2	7.1165	60.008
2025	11	8	14	22	15	25.52	95.6	7.1165	60.4842
2025	11	8	14	32	15	26.68	94.5	7.1165	63.3418
2025	11	8	14	42	15	26.16	93.7	7.1165	62.1511
2025	11	8	14	52	15	26.28	94.6	7.1165	62.3893
2025	11	8	15	2	15	24.31	95.4	7.1165	57.6267
2025	11	8	15	12	15	25.08	94.6	7.1165	59.5317
2025	11	8	15	22	15	25.2	95	7.1165	59.7699
2025	11	8	15	32	15	24.27	94.3	7.1165	57.6268
2025	11	8	15	42	15	25.52	95.6	7.1165	60.4843
2025	11	8	15	52	15	25.36	93.8	7.1165	60.2462

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	8	16	2	15	25.64	93.1	7.1165	60.9606
2025	11	8	16	12	15	25.85	96.2	7.1104	61.1439
2025	11	8	16	22	15	25.66	93.8	7.1165	60.9606
2025	11	8	16	32	15	25.87	94.2	7.1165	61.4369
2025	11	8	16	42	15	26.55	93.7	7.1165	63.1038
2025	11	8	16	52	15	24.96	93.9	7.1165	59.2938
2025	11	8	17	2	15	26.37	96.5	7.1165	62.3894
2025	11	8	17	12	15	25.5	95	7.1165	60.4844
2025	11	8	17	22	15	25.98	94.6	7.1165	61.6751
2025	11	8	17	32	15	25.05	96.2	7.1165	59.2938
2025	11	8	17	42	15	26.31	95.2	7.1165	62.3895
2025	11	8	17	52	15	26.17	94.2	7.1165	62.1513
2025	11	8	18	2	15	25.44	96.1	7.1165	60.2463
2025	11	8	18	12	15	25.59	94.7	7.1165	60.7226
2025	11	8	18	22	15	25.33	97.7	7.1165	59.7701
2025	11	8	18	32	15	25.41	95.4	7.1165	60.2464
2025	11	8	18	42	15	24.19	95	7.1165	57.3888
2025	11	8	18	52	15	24.93	95.8	7.1165	59.0558
2025	11	8	19	2	15	26.59	94.7	7.1165	63.1039
2025	11	8	19	12	15	26.68	94.5	7.1165	63.3421
2025	11	8	19	22	15	25.82	95.6	7.1165	61.199
2025	11	8	19	32	15	25.69	94.9	7.1226	61.0155
2025	11	8	19	42	15	25.95	96.2	7.1165	61.4371
2025	11	8	19	52	15	25.92	95.5	7.1165	61.4372
2025	11	8	20	2	15	25.76	93.8	7.1165	61.199
2025	11	8	20	12	15	25.99	94.9	7.1226	61.7306
2025	11	8	20	22	15	26.39	97	7.1165	62.3897
2025	11	8	20	32	15	25.36	93.8	7.1226	60.3006
2025	11	8	20	42	15	26.16	98.1	7.1165	61.6754
2025	11	8	20	52	15	25.97	94.2	7.1165	61.6754
2025	11	8	21	2	15	27.23	97.4	7.1165	64.2948
2025	11	8	21	12	15	26.06	96.4	7.1165	61.6754
2025	11	8	21	22	15	26.23	95.7	7.1226	62.2074
2025	11	8	21	32	15	25.26	94.1	7.1226	60.0623
2025	11	8	21	42	15	26.56	96.3	7.1226	62.9225
2025	11	8	21	52	15	27.33	95.7	7.1226	64.8292
2025	11	8	22	2	15	26.11	95.3	7.1165	61.9136
2025	11	8	22	12	15	25.92	95.5	7.1226	61.4925
2025	11	8	22	22	15	27.26	99.3	7.1226	64.1143
2025	11	8	22	32	15	26.47	96.5	7.1226	62.6842
2025	11	8	22	42	15	26.29	94.8	7.1226	62.4459
2025	11	8	22	52	15	26.02	95.5	7.1226	61.7309
2025	11	8	23	2	15	24.79	94.9	7.1226	58.8708
2025	11	8	23	12	15	27.61	97.1	7.1226	65.306
2025	11	8	23	22	15	27.16	96.1	7.1226	64.3527
2025	11	8	23	32	15	27.46	96.3	7.1165	65.0095
2025	11	8	23	42	15	25.65	96.3	7.1226	60.7776
2025	11	8	23	52	15	26.73	95.6	7.1226	63.3993

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	9	0	2	15	25.37	98.4	7.1226	59.8242
2025	11	9	0	12	15	25.08	94.6	7.1226	59.5859
2025	11	9	0	22	15	25.72	95.6	7.1226	61.0159
2025	11	9	0	32	15	26.18	94.4	7.1226	62.2077
2025	11	9	0	42	15	25.65	93.6	7.1226	61.0159
2025	11	9	0	52	15	25.95	93.5	7.1226	61.731
2025	11	9	1	2	15	27.9	96.8	7.1226	66.0212
2025	11	9	1	12	15	27.03	98.9	7.1226	63.6377
2025	11	9	1	22	15	25.15	93.6	7.1226	59.8242
2025	11	9	1	32	15	27.51	95.2	7.1226	65.3061
2025	11	9	1	42	15	26.97	98.1	7.1226	63.6377
2025	11	9	1	52	15	27.51	95.2	7.1226	65.3062
2025	11	9	2	2	15	24.75	96.3	7.1226	58.6325
2025	11	9	2	12	15	26.7	97.1	7.1226	63.1611
2025	11	9	2	22	15	26.76	96.2	7.1226	63.3994
2025	11	9	2	32	15	25.3	95	7.1226	60.0626
2025	11	9	2	42	15	25.42	95.6	7.1226	60.3009
2025	11	9	2	52	15	27.34	95.9	7.1226	64.8295
2025	11	9	3	2	15	25.73	95.8	7.1226	61.016
2025	11	9	3	12	15	25.85	98	7.1226	61.016
2025	11	9	3	22	15	26.08	96.8	7.1226	61.731
2025	11	9	3	32	15	26	95.1	7.1226	61.731
2025	11	9	3	42	15	26.38	94.6	7.1226	62.6844
2025	11	9	3	52	15	25.31	95.4	7.1226	60.0626
2025	11	9	4	2	15	26.46	93.9	7.1226	62.9227
2025	11	9	4	12	15	26.38	94.6	7.1226	62.6844
2025	11	9	4	22	15	26.87	96.4	7.1226	63.6377
2025	11	9	4	32	15	27.18	98.2	7.1226	64.1144
2025	11	9	4	42	15	26.58	96.7	7.1287	62.979
2025	11	9	4	52	15	26	95.1	7.1226	61.731
2025	11	9	5	2	15	26.5	95	7.1226	62.9227
2025	11	9	5	12	15	26.89	94.7	7.1287	63.9333
2025	11	9	5	22	15	26.26	96.3	7.1287	62.2634
2025	11	9	5	32	15	27.49	96.7	7.1287	65.1261
2025	11	9	5	42	15	26.5	98.7	7.1287	62.5019
2025	11	9	5	52	15	26.57	98.2	7.1287	62.7405
2025	11	9	6	2	15	25.72	95.6	7.1287	61.0706
2025	11	9	6	12	15	26.78	94.5	7.1287	63.6947
2025	11	9	6	22	15	26.78	94.5	7.1348	63.7517
2025	11	9	6	32	15	26.08	94.6	7.1348	62.0803
2025	11	9	6	42	15	27.38	96.5	7.1348	64.9455
2025	11	9	6	52	15	26.38	98.3	7.1348	62.3191
2025	11	9	7	2	15	26.32	95.5	7.1348	62.5578
2025	11	9	7	12	15	26.26	96.3	7.1348	62.3191
2025	11	9	7	22	15	26.67	98.2	7.1409	63.0917
2025	11	9	7	32	15	25.98	98.4	7.1348	61.364
2025	11	9	7	42	15	26.37	96.5	7.1348	62.5578
2025	11	9	7	52	15	27.4	96.9	7.1348	64.9455

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	9	8	2	15	26.41	95.2	7.1348	62.7966
2025	11	9	8	12	15	26.25	96.1	7.1409	62.3748
2025	11	9	8	22	15	26.05	96.2	7.1409	61.8968
2025	11	9	8	32	15	26.09	94.8	7.1409	62.1358
2025	11	9	8	42	15	26.7	97.1	7.1409	63.3307
2025	11	9	8	52	15	25.24	96.1	7.147	60.0385
2025	11	9	9	2	15	25.34	96.1	7.147	60.2776
2025	11	9	9	12	15	24.79	94.9	7.147	59.0816
2025	11	9	9	22	15	24.33	92.8	7.147	58.1248
2025	11	9	9	32	15	25.01	91.8	7.147	59.7992
2025	11	9	9	42	15	25.64	93.1	7.147	61.2343
2025	11	9	9	52	15	24.86	93.9	7.147	59.3207
2025	11	9	10	2	15	23.91	91.9	7.147	57.1679
2025	11	9	10	12	15	24.5	90.5	7.147	58.6031
2025	11	9	10	22	15	24.01	91.2	7.153	57.4583
2025	11	9	10	32	15	23.64	93.2	7.147	56.4503
2025	11	9	10	42	15	24.81	91.8	7.153	59.3736
2025	11	9	10	52	15	25	95	7.153	59.6129
2025	11	9	11	2	15	24.11	91.9	7.153	57.6976
2025	11	9	11	12	15	25.47	94.3	7.153	60.8099
2025	11	9	11	22	15	25.61	91.3	7.153	61.2887
2025	11	9	11	32	15	24.49	94.9	7.153	58.4158
2025	11	9	11	42	15	25.97	94.2	7.153	62.0069
2025	11	9	11	52	15	25.76	94	7.153	61.5281
2025	11	9	12	2	15	27.17	96.3	7.153	64.6404
2025	11	9	12	12	15	26.49	94.8	7.153	63.2039
2025	11	9	12	22	15	26.08	94.6	7.153	62.2463
2025	11	9	12	32	15	25.15	93.6	7.1591	60.1451
2025	11	9	12	42	15	26.04	96	7.153	62.0068
2025	11	9	12	52	15	25.32	95.7	7.1591	60.3848
2025	11	9	13	2	15	25.96	93.8	7.1591	62.0621
2025	11	9	13	12	15	25.49	94.7	7.1591	60.864
2025	11	9	13	22	15	24.77	94.2	7.1591	59.1866
2025	11	9	13	32	15	25.82	95.6	7.1591	61.5828
2025	11	9	13	42	15	25.29	94.8	7.1591	60.3847
2025	11	9	13	52	15	25.33	97.7	7.1591	60.1451
2025	11	9	14	2	15	25.36	93.8	7.1591	60.6243
2025	11	9	14	12	15	25.92	97.5	7.1591	61.5828
2025	11	9	14	22	15	25.14	93.2	7.1591	60.1451
2025	11	9	14	32	15	24.78	94.6	7.1591	59.1866
2025	11	9	14	42	15	26.27	96.6	7.1591	62.5413
2025	11	9	14	52	15	26.06	96.4	7.1591	62.0619
2025	11	9	15	2	15	25.53	92.9	7.1591	61.1035
2025	11	9	15	12	15	24.59	94.9	7.1591	58.7073
2025	11	9	15	22	15	25.86	96.4	7.1591	61.5827
2025	11	9	15	32	15	26.6	95	7.1591	63.4997
2025	11	9	15	42	15	26.22	95.5	7.1591	62.5413
2025	11	9	15	52	15	25.6	95.2	7.1591	61.1036

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	9	16	2	15	26.13	95.7	7.1591	62.3017
2025	11	9	16	12	15	25.73	95.8	7.1591	61.3432
2025	11	9	16	22	15	25.71	97.4	7.1591	61.1036
2025	11	9	16	32	15	25.63	95.8	7.1591	61.1036
2025	11	9	16	42	15	25.16	96.4	7.1591	59.9055
2025	11	9	16	52	15	25.65	93.6	7.1591	61.3433
2025	11	9	17	2	15	26.32	95.5	7.1591	62.781
2025	11	9	17	12	15	27.53	92.5	7.1591	65.8961
2025	11	9	17	22	15	25.26	93.9	7.1591	60.3848
2025	11	9	17	32	15	25.58	94.5	7.1591	61.1037
2025	11	9	17	42	15	25.71	95.4	7.1591	61.3433
2025	11	9	17	52	15	25.69	94.9	7.1591	61.3433
2025	11	9	18	2	15	25.36	94.1	7.1591	60.6245
2025	11	9	18	12	15	26.58	94.5	7.1591	63.5
2025	11	9	18	22	15	25.06	93.9	7.1591	59.9056
2025	11	9	18	32	15	26.14	97.7	7.1591	62.0623
2025	11	9	18	42	15	26.54	95.8	7.1591	63.2604
2025	11	9	18	52	15	26.01	97.3	7.1591	61.8227
2025	11	9	19	2	15	27.01	95.1	7.1591	64.4585
2025	11	9	19	12	15	26.84	95.8	7.1591	63.9793
2025	11	9	19	22	15	26.06	96.4	7.1591	62.0624
2025	11	9	19	32	15	27.05	95.9	7.1591	64.4586
2025	11	9	19	42	15	26.23	95.7	7.1591	62.5417
2025	11	9	19	52	15	26.86	96.2	7.1591	63.9794
2025	11	9	20	2	15	26.59	94.7	7.1591	63.5002
2025	11	9	20	12	15	26.25	96.1	7.1591	62.5417
2025	11	9	20	22	15	25.44	97.9	7.1591	60.3851
2025	11	9	20	32	15	26.34	95.9	7.1591	62.7814
2025	11	9	20	42	15	26.53	95.6	7.1591	63.2607
2025	11	9	20	52	15	27.48	98.2	7.1591	65.1777
2025	11	9	21	2	15	26.23	95.7	7.1591	62.5419
2025	11	9	21	12	15	26.06	96.4	7.1591	62.0626
2025	11	9	21	22	15	27.76	96.2	7.1591	66.1363
2025	11	9	21	32	15	26.16	96.4	7.1591	62.3023
2025	11	9	21	42	15	24.39	97.1	7.1591	57.9891
2025	11	9	21	52	15	26.46	96.3	7.1591	63.0212
2025	11	9	22	2	15	25.09	94.8	7.1591	59.9061
2025	11	9	22	12	15	26.23	97.7	7.1591	62.3024
2025	11	9	22	22	15	26.22	95.5	7.1591	62.542
2025	11	9	22	32	15	25.88	94.4	7.1591	61.8232
2025	11	9	22	42	15	25.2	97.3	7.1591	59.9062
2025	11	9	22	52	15	24.97	94.4	7.1591	59.6666
2025	11	9	23	2	15	25.77	94.2	7.153	61.5288
2025	11	9	23	12	15	27.1	97	7.1591	64.4591
2025	11	9	23	22	15	26.11	95.3	7.1591	62.3025
2025	11	9	23	32	15	26.72	95.4	7.1591	63.7403
2025	11	9	23	42	15	26.86	97.9	7.1591	63.7403
2025	11	9	23	52	15	25.9	95.1	7.1591	61.8233

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	10	0	2	15	25.87	94.2	7.1591	61.8233
2025	11	10	0	12	15	27.41	95	7.153	65.3595
2025	11	10	0	22	15	26.51	97.2	7.153	62.9653
2025	11	10	0	32	15	25.64	96	7.153	61.05
2025	11	10	0	42	15	27.03	97.4	7.1591	64.2196
2025	11	10	0	52	15	26.22	95.5	7.153	62.4865
2025	11	10	1	2	15	27.15	97.8	7.153	64.4018
2025	11	10	1	12	15	26.36	96.3	7.153	62.726
2025	11	10	1	22	15	26.16	96.4	7.153	62.2471
2025	11	10	1	32	15	25.57	96.5	7.153	60.8107
2025	11	10	1	42	15	26.72	95.4	7.153	63.6836
2025	11	10	1	52	15	27.53	95.6	7.153	65.5989
2025	11	10	2	2	15	26.73	92.8	7.153	63.923
2025	11	10	2	12	15	26.85	96	7.153	63.923
2025	11	10	2	22	15	26.69	96.9	7.153	63.4442
2025	11	10	2	32	15	26.71	95.2	7.153	63.6836
2025	11	10	2	42	15	27.27	96.3	7.153	64.8807
2025	11	10	2	52	15	26.94	95.8	7.153	64.1624
2025	11	10	3	2	15	27.02	95.3	7.153	64.4019
2025	11	10	3	12	15	26.68	94.5	7.153	63.6836
2025	11	10	3	22	15	24.85	93.7	7.153	59.3742
2025	11	10	3	32	15	26.86	96.2	7.153	63.923
2025	11	10	3	42	15	27.45	93.6	7.153	65.5989
2025	11	10	3	52	15	27.41	95.2	7.153	65.3595
2025	11	10	4	2	15	27.73	95.6	7.153	66.0777
2025	11	10	4	12	15	26.02	95.5	7.153	62.0077
2025	11	10	4	22	15	25.98	94.6	7.153	62.0077
2025	11	10	4	32	15	26.64	95.8	7.153	63.4442
2025	11	10	4	42	15	25.47	96.5	7.153	60.5713
2025	11	10	4	52	15	27.17	96.3	7.153	64.6413
2025	11	10	5	2	15	26.39	94.8	7.153	62.9654
2025	11	10	5	12	15	27.09	94.7	7.153	64.6413
2025	11	10	5	22	15	26.38	94.3	7.153	62.9654
2025	11	10	5	32	15	26.04	93.1	7.153	62.2471
2025	11	10	5	42	15	24.77	94.4	7.153	59.1348
2025	11	10	5	52	15	23.74	93.1	7.153	56.7407
2025	11	10	6	2	15	26.03	92.6	7.153	62.2471
2025	11	10	6	12	15	26.13	92.9	7.153	62.4866
2025	11	10	6	22	15	24.85	93.7	7.153	59.3742
2025	11	10	6	32	15	24.8	95.1	7.153	59.1348
2025	11	10	6	42	15	25.87	94.2	7.153	61.7683
2025	11	10	6	52	15	26.02	92	7.153	62.2471
2025	11	10	7	2	15	25.62	95.6	7.153	61.0501
2025	11	10	7	12	15	25.27	96.6	7.153	60.0924
2025	11	10	7	22	15	26.53	95.6	7.153	63.2048
2025	11	10	7	32	15	25.78	94.4	7.153	61.5289
2025	11	10	7	42	15	26.17	96.6	7.153	62.2472
2025	11	10	7	52	15	25.68	94.5	7.153	61.2895

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	10	8	2	15	24.79	94.9	7.153	59.1348
2025	11	10	8	12	15	24.93	92.8	7.153	59.6136
2025	11	10	8	22	15	26.05	93.5	7.153	62.2472
2025	11	10	8	32	15	25.02	92.5	7.153	59.853
2025	11	10	8	42	15	23.65	93.6	7.153	56.5013
2025	11	10	8	52	15	25.44	93.4	7.153	60.8107
2025	11	10	9	2	15	24.44	93.3	7.153	58.4165
2025	11	10	9	12	15	25.59	94.7	7.153	61.05
2025	11	10	9	22	15	25.59	94.9	7.153	61.05
2025	11	10	9	32	15	25.44	93.2	7.153	60.8106
2025	11	10	9	42	15	24.42	92.6	7.153	58.4164
2025	11	10	9	52	15	25.35	93.6	7.153	60.5711
2025	11	10	10	2	15	24.25	93.5	7.153	57.9376
2025	11	10	10	12	15	24.61	91.9	7.153	58.8952
2025	11	10	10	22	15	25	90.7	7.1591	59.9062
2025	11	10	10	32	15	24.88	94.6	7.153	59.374
2025	11	10	10	42	15	25.41	91.8	7.153	60.8104
2025	11	10	10	52	15	24.22	92.1	7.153	57.9375
2025	11	10	11	2	15	24	91	7.153	57.4586
2025	11	10	11	12	15	24.8	90.9	7.153	59.3739
2025	11	10	11	22	15	25.47	94.3	7.153	60.8103
2025	11	10	11	32	15	25	90.2	7.153	59.8527
2025	11	10	11	42	15	23.43	92.9	7.153	56.0221
2025	11	10	11	52	15	25.95	93.5	7.153	62.0074
2025	11	10	12	2	15	24.76	93.9	7.153	59.1344
2025	11	10	12	12	15	26.18	94.6	7.153	62.4861
2025	11	10	12	22	15	25.29	94.8	7.153	60.3314
2025	11	10	12	32	15	24.13	92.6	7.1591	57.7493
2025	11	10	12	42	15	25.2	95	7.1591	60.1455
2025	11	10	12	52	15	25.46	93.8	7.1591	60.8644
2025	11	10	13	2	15	25.22	92.5	7.153	60.3314
2025	11	10	13	12	15	26.32	95.5	7.153	62.7254
2025	11	10	13	22	15	25.53	92.7	7.153	61.0496
2025	11	10	13	32	15	24.33	95.9	7.153	57.9372
2025	11	10	13	42	15	26.12	95.5	7.153	62.2466
2025	11	10	13	52	15	24.22	92.4	7.153	57.9372
2025	11	10	14	2	15	24.55	93.5	7.153	58.6554
2025	11	10	14	12	15	24.76	93.9	7.153	59.1342
2025	11	10	14	22	15	24.21	91.7	7.153	57.9372
2025	11	10	14	32	15	23.8	91	7.153	56.9796
2025	11	10	14	42	15	24.15	93.8	7.153	57.6978
2025	11	10	14	52	15	24.71	91.4	7.153	59.1342
2025	11	10	15	2	15	23.99	95	7.147	57.1679
2025	11	10	15	12	15	24.99	94.8	7.147	59.5599
2025	11	10	15	22	15	24.31	91.7	7.153	58.1766
2025	11	10	15	32	15	24.56	94	7.147	58.6031
2025	11	10	15	42	15	24.7	90.9	7.147	59.0815
2025	11	10	15	52	15	24.7	90.9	7.147	59.0816

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	10	16	2	15	24.52	92.3	7.147	58.6032
2025	11	10	16	12	15	24.51	91.6	7.147	58.6032
2025	11	10	16	22	15	25.1	91.1	7.147	60.0384
2025	11	10	16	32	15	24.75	93.5	7.147	59.0816
2025	11	10	16	42	15	24.42	92.6	7.1409	58.3119
2025	11	10	16	52	15	24.13	92.9	7.147	57.6464
2025	11	10	17	2	15	24.91	91.8	7.147	59.56
2025	11	10	17	12	15	23.7	90.5	7.1409	56.639
2025	11	10	17	22	15	23.77	94.3	7.1409	56.639
2025	11	10	17	32	15	24.51	91.2	7.1348	58.4986
2025	11	10	17	42	15	23.7	90	7.1348	56.5885
2025	11	10	17	52	15	24.4	89.8	7.1348	58.2599
2025	11	10	18	2	15	23.61	91.9	7.1348	56.3497
2025	11	10	18	12	15	24.3	90.9	7.1287	57.9693
2025	11	10	18	22	15	24.6	90.9	7.1287	58.685
2025	11	10	18	32	15	23.51	91.2	7.1226	56.0107
2025	11	10	18	42	15	24.21	91.9	7.1287	57.7308
2025	11	10	18	52	15	24.25	93.5	7.1287	57.7308
2025	11	10	19	2	15	24.2	90.9	7.1287	57.7308
2025	11	10	19	12	15	24.42	92.1	7.1226	58.1559
2025	11	10	19	22	15	24.33	92.8	7.1226	57.9176
2025	11	10	19	32	15	24.64	93.3	7.1226	58.6326
2025	11	10	19	42	15	24.7	90.2	7.1226	58.871
2025	11	10	19	52	15	25.26	93.9	7.1226	60.0627
2025	11	10	20	2	15	24.65	93.7	7.1226	58.6327
2025	11	10	20	12	15	25.02	92.1	7.1226	59.5861
2025	11	10	20	22	15	24.62	92.6	7.1226	58.6327
2025	11	10	20	32	15	24.22	92.4	7.1226	57.6794
2025	11	10	20	42	15	25.04	93.2	7.1165	59.5328
2025	11	10	20	52	15	25.53	95.8	7.1165	60.4853
2025	11	10	21	2	15	24.41	91.9	7.1165	58.104
2025	11	10	21	12	15	25.65	93.6	7.1165	60.9616
2025	11	10	21	22	15	25.78	94.4	7.1165	61.1998
2025	11	10	21	32	15	25.1	90	7.1165	59.771
2025	11	10	21	42	15	26.35	93.5	7.1165	62.6286
2025	11	10	21	52	15	25.33	92.7	7.1165	60.2473
2025	11	10	22	2	15	24.4	90.7	7.1165	58.1042
2025	11	10	22	12	15	24.53	92.8	7.1165	58.3423
2025	11	10	22	22	15	23.85	93.6	7.1104	56.6246
2025	11	10	22	32	15	24.77	94.4	7.1165	58.8186
2025	11	10	22	42	15	24.92	92.5	7.1104	59.2418
2025	11	10	22	52	15	23.87	94.3	7.1104	56.6247
2025	11	10	23	2	15	25.76	93.8	7.1104	61.1451
2025	11	10	23	12	15	26.15	93.5	7.1104	62.0968
2025	11	10	23	22	15	26	95.1	7.1104	61.621
2025	11	10	23	32	15	24.14	93.3	7.1104	57.3385
2025	11	10	23	42	15	26.38	94.3	7.1104	62.5727
2025	11	10	23	52	15	26.33	95.7	7.1104	62.3348

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	11	0	2	15	25.89	94.9	7.1104	61.3831
2025	11	11	0	12	15	24.44	93.3	7.1104	58.0523
2025	11	11	0	22	15	26.41	95.2	7.1104	62.5728
2025	11	11	0	32	15	25.8	95.1	7.1104	61.1452
2025	11	11	0	42	15	25.43	92.9	7.1104	60.4315
2025	11	11	0	52	15	26.77	96.4	7.1104	63.2865
2025	11	11	1	2	15	27	94.9	7.1043	63.9429
2025	11	11	1	12	15	26.08	96.8	7.1104	61.6211
2025	11	11	1	22	15	26.2	97	7.1043	61.8036
2025	11	11	1	32	15	24.71	95.3	7.1104	58.5282
2025	11	11	1	42	15	25.84	96	7.1104	61.1453
2025	11	11	1	52	15	25.91	97.3	7.1043	61.0904
2025	11	11	2	2	15	24.89	94.8	7.1043	58.9511
2025	11	11	2	12	15	26.07	94.2	7.1104	61.859
2025	11	11	2	22	15	26.03	95.7	7.1043	61.5659
2025	11	11	2	32	15	25.87	94.2	7.1043	61.3282
2025	11	11	2	42	15	26.72	95.4	7.1043	63.2298
2025	11	11	2	52	15	26.69	96.9	7.1043	62.9921
2025	11	11	3	2	15	26.41	97.2	7.1043	62.279
2025	11	11	3	12	15	25.81	95.3	7.1043	61.0904
2025	11	11	3	22	15	26.7	97.1	7.1043	62.9921
2025	11	11	3	32	15	25.42	95.6	7.1043	60.1396
2025	11	11	3	42	15	27.07	96.4	7.1043	63.9429
2025	11	11	3	52	15	26.88	96.6	7.1043	63.4675
2025	11	11	4	2	15	26.6	95	7.1043	62.9921
2025	11	11	4	12	15	25.89	96.9	7.1043	61.0904
2025	11	11	4	22	15	26.72	97.3	7.1043	62.9921
2025	11	11	4	32	15	26.31	95.2	7.1043	62.279
2025	11	11	4	42	15	26.66	96.2	7.0982	62.9355
2025	11	11	4	52	15	25.3	95	7.1043	59.9019
2025	11	11	5	2	15	26.77	96.4	7.1043	63.2298
2025	11	11	5	12	15	26	97.1	7.1043	61.3281
2025	11	11	5	22	15	26.22	95.5	7.0982	61.9855
2025	11	11	5	32	15	25.83	95.8	7.1043	61.0904
2025	11	11	5	42	15	26.46	96.3	7.1043	62.5166
2025	11	11	5	52	15	25.41	95.4	7.1043	60.1396
2025	11	11	6	2	15	25.92	97.5	7.1043	61.0904
2025	11	11	6	12	15	26.36	98.1	7.0982	61.9855
2025	11	11	6	22	15	26.09	94.8	7.0982	61.748
2025	11	11	6	32	15	26.12	97.5	7.0982	61.5105
2025	11	11	6	42	15	27.4	96.9	7.1043	64.656
2025	11	11	6	52	15	26.51	95.2	7.1043	62.7543
2025	11	11	7	2	15	26.77	96.4	7.0982	63.173
2025	11	11	7	12	15	26.95	99.2	7.0982	63.173
2025	11	11	7	22	15	26.58	96.7	7.0982	62.698
2025	11	11	7	32	15	26.72	97.3	7.0982	62.9355
2025	11	11	7	42	15	25.51	97.4	7.0982	60.0856
2025	11	11	7	52	15	26.45	99.4	7.0982	61.9855

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	11	8	2	15	25.32	95.7	7.0982	59.8481
2025	11	11	8	12	15	25.86	96.4	7.0982	61.0355
2025	11	11	8	22	15	26.08	98.4	7.0982	61.273
2025	11	11	8	32	15	25.53	97.7	7.1043	60.1395
2025	11	11	8	42	15	25.97	96.6	7.0982	61.273
2025	11	11	8	52	15	25.83	95.8	7.0982	61.0355
2025	11	11	9	2	15	25.57	94.3	7.0982	60.5605
2025	11	11	9	12	15	25.07	96.6	7.0982	59.1355
2025	11	11	9	22	15	24.83	95.8	7.0982	58.6605
2025	11	11	9	32	15	24.97	96.7	7.0982	58.898
2025	11	11	9	42	15	26.23	95.7	7.0982	61.9854
2025	11	11	9	52	15	25.68	96.7	7.0982	60.5604
2025	11	11	10	2	15	25.5	95.2	7.0982	60.3229
2025	11	11	10	12	15	25.55	96.3	7.0982	60.3229
2025	11	11	10	22	15	25.7	95.1	7.0982	60.7978
2025	11	11	10	32	15	25.04	93.2	7.1043	59.4262
2025	11	11	10	42	15	25.01	95.3	7.0982	59.1354
2025	11	11	10	52	15	25.47	96.5	7.0982	60.0853
2025	11	11	11	2	15	25.12	95.7	7.0982	59.3728
2025	11	11	11	12	15	24.57	96.8	7.0982	57.9478
2025	11	11	11	22	15	25.82	95.6	7.0982	61.0352
2025	11	11	11	32	15	24.71	95.3	7.1043	58.4753
2025	11	11	11	42	15	25.58	94.5	7.1043	60.6146
2025	11	11	11	52	15	25.96	94	7.1043	61.5654
2025	11	11	12	2	15	24.39	94.9	7.1043	57.7621
2025	11	11	12	12	15	22.9	89.7	7.1043	54.4342
2025	11	11	12	22	15	23.44	93.2	7.1043	55.6227
2025	11	11	12	32	15	23.33	92.7	7.1043	55.385
2025	11	11	12	42	15	26.16	93.9	7.0982	61.985
2025	11	11	12	52	15	25.59	94.9	7.0982	60.5601
2025	11	11	13	2	15	25.91	95.3	7.1043	61.3276
2025	11	11	13	12	15	25.55	93.6	7.1043	60.6145
2025	11	11	13	22	15	25.14	93.4	7.1043	59.6637
2025	11	11	13	32	15	23.71	91.9	7.1043	56.3358
2025	11	11	13	42	15	25.03	92.7	7.0982	59.3726
2025	11	11	13	52	15	24.7	95.1	7.0982	58.4227
2025	11	11	14	2	15	25.06	94.1	7.0982	59.3726
2025	11	11	14	12	15	25.45	96.3	7.0982	60.0851
2025	11	11	14	22	15	27.32	95.5	7.0982	64.5974
2025	11	11	14	32	15	26.84	95.8	7.1043	63.4668
2025	11	11	14	42	15	25.96	96.4	7.0982	61.2725
2025	11	11	14	52	15	24.75	96.3	7.0982	58.4226
2025	11	11	15	2	15	26.02	97.5	7.0982	61.2725
2025	11	11	15	12	15	25.17	96.6	7.0982	59.3726
2025	11	11	15	22	15	25.52	95.6	7.0982	60.3225
2025	11	11	15	32	15	23.96	94.1	7.0982	56.7602
2025	11	11	15	42	15	26.01	97.3	7.0982	61.2725
2025	11	11	15	52	15	24.02	95.7	7.0982	56.7602

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	11	16	2	15	24.87	96.7	7.0982	58.6601
2025	11	11	16	12	15	25.38	94.5	7.0982	60.0851
2025	11	11	16	22	15	26.28	96.8	7.0982	61.985
2025	11	11	16	32	15	26.42	97.4	7.0982	62.2225
2025	11	11	16	42	15	26.59	98.4	7.0982	62.46
2025	11	11	16	52	15	24.97	96.7	7.0982	58.8976
2025	11	11	17	2	15	26.85	96	7.0982	63.41
2025	11	11	17	12	15	26.09	98.6	7.0982	61.2726
2025	11	11	17	22	15	26.4	95	7.0982	62.46
2025	11	11	17	32	15	25.84	96	7.0982	61.0351
2025	11	11	17	42	15	25.79	96.9	7.0982	60.7976
2025	11	11	17	52	15	26.42	95.4	7.0982	62.4601
2025	11	11	18	2	15	26.21	97.2	7.0982	61.7476
2025	11	11	18	12	15	28.16	97.8	7.0982	66.2599
2025	11	11	18	22	15	24.96	96.4	7.0982	58.8977
2025	11	11	18	32	15	24.59	94.9	7.0982	58.1853
2025	11	11	18	42	15	24.87	96.7	7.0982	58.6603
2025	11	11	18	52	15	25.85	98	7.0982	60.7977
2025	11	11	19	2	15	25.32	95.7	7.0982	59.8477
2025	11	11	19	12	15	26.46	96.3	7.0982	62.4601
2025	11	11	19	22	15	25.23	95.9	7.0982	59.6103
2025	11	11	19	32	15	26.23	97.7	7.0921	61.6922
2025	11	11	19	42	15	26.9	97	7.0921	63.3532
2025	11	11	19	52	15	27.43	95.6	7.0982	64.8351
2025	11	11	20	2	15	25.91	95.3	7.0921	61.2177
2025	11	11	20	12	15	25.91	97.3	7.0982	61.0353
2025	11	11	20	22	15	25.49	97	7.0982	60.0853
2025	11	11	20	32	15	25.79	96.9	7.0921	60.7432
2025	11	11	20	42	15	25.53	97.7	7.0921	60.0314
2025	11	11	20	52	15	26.62	97.3	7.0921	62.6415
2025	11	11	21	2	15	25.92	95.5	7.0921	61.2178
2025	11	11	21	12	15	26.22	95.5	7.0921	61.9297
2025	11	11	21	22	15	26.68	94.5	7.0921	63.1161
2025	11	11	21	32	15	26.28	96.8	7.0921	61.9297
2025	11	11	21	42	15	25.61	95.4	7.0921	60.506
2025	11	11	21	52	15	25.63	97.6	7.0921	60.2688
2025	11	11	22	2	15	25.27	96.6	7.0921	59.5569
2025	11	11	22	12	15	25.4	95.2	7.0921	60.0315
2025	11	11	22	22	15	25.18	96.8	7.0921	59.3197
2025	11	11	22	32	15	26.2	97	7.0921	61.6925
2025	11	11	22	42	15	26.25	96.1	7.0921	61.9298
2025	11	11	22	52	15	27.1	97	7.0921	63.828
2025	11	11	23	2	15	25.92	97.5	7.0921	60.9807
2025	11	11	23	12	15	25.87	96.7	7.0921	60.9807
2025	11	11	23	22	15	26.86	97.9	7.0921	63.1162
2025	11	11	23	32	15	25.03	95.7	7.0921	59.0825
2025	11	11	23	42	15	25.59	94.9	7.0921	60.5062
2025	11	11	23	52	15	25.34	96.1	7.0921	59.7943

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	12	0	2	15	25.94	97.8	7.0921	60.9807
2025	11	12	0	12	15	24.62	97.7	7.0921	57.8961
2025	11	12	0	22	15	25.48	96.8	7.0921	60.0316
2025	11	12	0	32	15	25.9	97.1	7.0921	60.9808
2025	11	12	0	42	15	25.44	97.9	7.0921	59.7944
2025	11	12	0	52	15	26.46	96.3	7.0921	62.4044
2025	11	12	1	2	15	25.89	94.9	7.0921	61.218
2025	11	12	1	12	15	25.13	97.8	7.0921	59.0825
2025	11	12	1	22	15	25.09	94.8	7.0921	59.3198
2025	11	12	1	32	15	26.69	98.4	7.0921	62.6417
2025	11	12	1	42	15	26.06	98.2	7.0921	61.218
2025	11	12	1	52	15	25.49	97	7.0921	60.0316
2025	11	12	2	2	15	25.01	95.3	7.0921	59.0825
2025	11	12	2	12	15	27.2	98.5	7.0921	63.8281
2025	11	12	2	22	15	27.48	98.2	7.0921	64.5399
2025	11	12	2	32	15	26.57	99.5	7.0921	62.1671
2025	11	12	2	42	15	26.28	98.3	7.0921	61.6926
2025	11	12	2	52	15	26.38	96.7	7.0921	62.1671
2025	11	12	3	2	15	27.33	97.4	7.0921	64.3026
2025	11	12	3	12	15	25.55	98.1	7.0921	60.0316
2025	11	12	3	22	15	26.33	92.6	7.0921	62.4044
2025	11	12	3	32	15	27.1	97	7.0921	63.828
2025	11	12	3	42	15	27.21	97.2	7.0921	64.0653
2025	11	12	3	52	15	26.59	94.7	7.0921	62.8789
2025	11	12	4	2	15	25.92	95.5	7.0921	61.218
2025	11	12	4	12	15	27.25	96.1	7.0921	64.3026
2025	11	12	4	22	15	25.21	95.2	7.0921	59.557
2025	11	12	4	32	15	25.47	96.5	7.0921	60.0315
2025	11	12	4	42	15	25.66	96.5	7.0982	60.5605
2025	11	12	4	52	15	26.04	97.7	7.0982	61.273
2025	11	12	5	2	15	26.32	95.5	7.0982	62.2229
2025	11	12	5	12	15	26.14	95.9	7.0982	61.7479
2025	11	12	5	22	15	26.32	97.4	7.0982	61.9854
2025	11	12	5	32	15	27.08	94.4	7.0982	64.1228
2025	11	12	5	42	15	26.29	94.8	7.0982	62.2229
2025	11	12	5	52	15	26	95.1	7.0982	61.5104
2025	11	12	6	2	15	25.15	96.2	7.0982	59.373
2025	11	12	6	12	15	25.15	96.2	7.0982	59.3729
2025	11	12	6	22	15	25.72	95.6	7.0982	60.7979
2025	11	12	6	32	15	25.44	96.1	7.0982	60.0854
2025	11	12	6	42	15	26.32	95.5	7.0982	62.2228
2025	11	12	6	52	15	27.34	95.9	7.0982	64.5977
2025	11	12	7	2	15	26.66	96.2	7.0982	62.9352
2025	11	12	7	12	15	25.84	96	7.0982	61.0353
2025	11	12	7	22	15	26.25	96.1	7.0982	61.9853
2025	11	12	7	32	15	26.92	95.3	7.0982	63.6477
2025	11	12	7	42	15	25.57	94.3	7.0982	60.5603
2025	11	12	7	52	15	25.48	96.8	7.0982	60.0853

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	12	8	2	15	26.76	96.2	7.0982	63.1727
2025	11	12	8	12	15	26.15	97.9	7.1043	61.5655
2025	11	12	8	22	15	25.4	95.2	7.0982	60.0852
2025	11	12	8	32	15	26.76	96.2	7.1043	63.2294
2025	11	12	8	42	15	26.86	97.9	7.1043	63.2294
2025	11	12	8	52	15	25.84	96	7.1043	61.09
2025	11	12	9	2	15	27.17	96.3	7.1043	64.1802
2025	11	12	9	12	15	26.61	95.2	7.1043	62.9916
2025	11	12	9	22	15	26	97.1	7.1043	61.3277
2025	11	12	9	32	15	26.9	97	7.1043	63.467
2025	11	12	9	42	15	25.42	95.6	7.1043	60.1391
2025	11	12	9	52	15	26.58	96.7	7.1043	62.7539
2025	11	12	10	2	15	26.79	94.7	7.1043	63.4669
2025	11	12	10	12	15	24.91	97.4	7.1104	58.7656
2025	11	12	10	22	15	28.14	95.7	7.1043	66.5571
2025	11	12	10	32	15	25.39	94.7	7.1104	60.193
2025	11	12	10	42	15	26.96	97.9	7.1043	63.4669
2025	11	12	10	52	15	26.38	94.6	7.1104	62.5722
2025	11	12	11	2	15	27.05	97.9	7.1104	63.7618
2025	11	12	11	12	15	26.43	95.6	7.1104	62.5722
2025	11	12	11	22	15	27.55	96	7.1104	65.1892
2025	11	12	11	32	15	26.7	97.1	7.1104	63.048
2025	11	12	11	42	15	27.2	97	7.1104	64.2375
2025	11	12	11	52	15	26.8	98.6	7.1104	63.0479
2025	11	12	12	2	15	26.9	97	7.1104	63.5238
2025	11	12	12	12	15	26.63	99.1	7.1104	62.5721
2025	11	12	12	22	15	26.02	97.5	7.1104	61.3825
2025	11	12	12	32	15	26.16	98.1	7.1165	61.6757
2025	11	12	12	42	15	27.14	97.6	7.1165	64.057
2025	11	12	12	52	15	27.75	97.7	7.1165	65.4857
2025	11	12	13	2	15	26.51	97.2	7.1165	62.6281
2025	11	12	13	12	15	26.56	96.3	7.1165	62.8662
2025	11	12	13	22	15	26.67	98.2	7.1165	62.8662
2025	11	12	13	32	15	26.31	97.2	7.1165	62.1518
2025	11	12	13	42	15	25.97	94.2	7.1165	61.6755
2025	11	12	13	52	15	25.62	95.6	7.1165	60.723
2025	11	12	14	2	15	24.86	93.9	7.1165	59.0561
2025	11	12	14	12	15	25.33	92.7	7.1165	60.2467
2025	11	12	14	22	15	25.71	95.4	7.1165	60.9611
2025	11	12	14	32	15	23.79	95.1	7.1226	56.4872
2025	11	12	14	42	15	24.83	93	7.1165	59.056
2025	11	12	14	52	15	24.83	92.8	7.1165	59.0561
2025	11	12	15	2	15	24.73	95.8	7.1226	58.6323
2025	11	12	15	12	15	24.85	96.2	7.1226	58.8706
2025	11	12	15	22	15	24.69	94.9	7.1226	58.6323
2025	11	12	15	32	15	25.47	98.4	7.1226	60.0624
2025	11	12	15	42	15	25.6	95.2	7.1226	60.7774
2025	11	12	15	52	15	24.8	95.1	7.1226	58.8707

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	12	16	2	15	25.57	96.5	7.1226	60.5391
2025	11	12	16	12	15	25.14	93.4	7.1226	59.8241
2025	11	12	16	22	15	24.43	95.9	7.1226	57.9173
2025	11	12	16	32	15	24.79	94.9	7.1287	58.9234
2025	11	12	16	42	15	25.27	96.6	7.1226	59.8241
2025	11	12	16	52	15	24.97	96.7	7.1226	59.1091
2025	11	12	17	2	15	25.13	95.9	7.1226	59.5857
2025	11	12	17	12	15	24.79	94.9	7.1226	58.8707
2025	11	12	17	22	15	26.28	96.8	7.1226	62.2075
2025	11	12	17	32	15	25.66	96.5	7.1287	60.8319
2025	11	12	17	42	15	26.09	94.8	7.1226	61.9692
2025	11	12	17	52	15	25.27	94.3	7.1226	60.0624
2025	11	12	18	2	15	26.41	97.2	7.1226	62.4459
2025	11	12	18	12	15	26.82	97.3	7.1226	63.3993
2025	11	12	18	22	15	26.55	96.1	7.1226	62.9226
2025	11	12	18	32	15	26.38	94.6	7.1226	62.6842
2025	11	12	18	42	15	27.19	96.8	7.1226	64.3527
2025	11	12	18	52	15	26.23	95.7	7.1226	62.2076
2025	11	12	19	2	15	25.65	96.3	7.1226	60.7775
2025	11	12	19	12	15	25.58	94.5	7.1287	60.8319
2025	11	12	19	22	15	26.18	94.6	7.1287	62.2633
2025	11	12	19	32	15	25.31	95.4	7.1226	60.0625
2025	11	12	19	42	15	24.85	93.5	7.1226	59.1091
2025	11	12	19	52	15	26.02	95.5	7.1287	61.7862
2025	11	12	20	2	15	26.06	96.4	7.1287	61.7862
2025	11	12	20	12	15	28.05	97.6	7.1348	66.3781
2025	11	12	20	22	15	27.4	96.9	7.1348	64.9455
2025	11	12	20	32	15	26.97	96.4	7.1409	64.0476
2025	11	12	20	42	15	27.75	97.7	7.147	65.7792
2025	11	12	20	52	15	27.34	99	7.147	64.5832
2025	11	12	21	2	15	26.49	96.9	7.147	62.9088
2025	11	12	21	12	15	26.08	96.8	7.1409	61.8968
2025	11	12	21	22	15	25.14	98	7.147	59.5601
2025	11	12	21	32	15	27.71	95.2	7.147	66.0184
2025	11	12	21	42	15	26.84	95.8	7.147	63.8657
2025	11	12	21	52	15	26.66	96.2	7.153	63.4438
2025	11	12	22	2	15	26.51	97.2	7.147	62.9089
2025	11	12	22	12	15	27.03	97.4	7.147	64.1049
2025	11	12	22	22	15	27.2	94.9	7.153	64.8803
2025	11	12	22	32	15	25.51	97.4	7.147	60.517
2025	11	12	22	42	15	27.82	97.2	7.153	66.0774
2025	11	12	22	52	15	26.32	95.5	7.153	62.7257
2025	11	12	23	2	15	26.58	96.7	7.153	63.2045
2025	11	12	23	12	15	26.28	94.6	7.153	62.7257
2025	11	12	23	22	15	26.26	96.3	7.153	62.4863
2025	11	12	23	32	15	25.9	95.1	7.153	61.768
2025	11	12	23	42	15	26.89	96.8	7.153	63.9227
2025	11	12	23	52	15	27.28	96.5	7.153	64.8804

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	13	0	2	15	25.95	96.2	7.153	61.7681
2025	11	13	0	12	15	25.66	94	7.147	61.2346
2025	11	13	0	22	15	25.32	95.7	7.147	60.2778
2025	11	13	0	32	15	26.18	94.6	7.1409	62.3749
2025	11	13	0	42	15	26.48	94.5	7.147	63.1482
2025	11	13	0	52	15	26.82	95.3	7.147	63.8658
2025	11	13	1	2	15	25.17	96.6	7.147	59.7994
2025	11	13	1	12	15	26.18	94.4	7.1409	62.3749
2025	11	13	1	22	15	25.7	97.2	7.147	60.9954
2025	11	13	1	32	15	26.25	96.1	7.153	62.4863
2025	11	13	1	42	15	24.16	96.7	7.147	57.4074
2025	11	13	1	52	15	26.45	96.1	7.1591	63.0212
2025	11	13	2	2	15	27.35	96.1	7.1591	65.1778
2025	11	13	2	12	15	26.53	95.6	7.1591	63.2608
2025	11	13	2	22	15	26.11	95.3	7.1591	62.3023
2025	11	13	2	32	15	26.08	96.8	7.1591	62.0627
2025	11	13	2	42	15	27.13	95.7	7.1591	64.6985
2025	11	13	2	52	15	25.49	94.7	7.153	60.8103
2025	11	13	3	2	15	25.92	95.5	7.153	61.768
2025	11	13	3	12	15	25.46	93.8	7.153	60.8103
2025	11	13	3	22	15	25.43	95.9	7.153	60.5709
2025	11	13	3	32	15	26.76	96.2	7.1652	63.7967
2025	11	13	3	42	15	26.04	96	7.1652	62.1179
2025	11	13	3	52	15	26.06	96.4	7.1652	62.1179
2025	11	13	4	2	15	26.62	95.4	7.1652	63.5569
2025	11	13	4	12	15	26.09	94.8	7.1652	62.3577
2025	11	13	4	22	15	27.3	96.9	7.1652	64.9959
2025	11	13	4	32	15	26.53	95.6	7.1652	63.317
2025	11	13	4	42	15	26.56	96.3	7.1652	63.317
2025	11	13	4	52	15	27.25	96.1	7.1652	64.9959
2025	11	13	5	2	15	26.97	98.1	7.1652	64.0365
2025	11	13	5	12	15	26.39	97	7.1652	62.8373
2025	11	13	5	22	15	26.87	96.4	7.1652	64.0365
2025	11	13	5	32	15	26.83	95.6	7.1652	64.0365
2025	11	13	5	42	15	25.37	96.6	7.1652	60.4389
2025	11	13	5	52	15	26.05	96.2	7.1652	62.1178
2025	11	13	6	2	15	27.84	95.8	7.1652	66.4349
2025	11	13	6	12	15	26.01	95.3	7.1652	62.1178
2025	11	13	6	22	15	26.31	95.2	7.1652	62.8373
2025	11	13	6	32	15	27.66	96.2	7.1652	65.9552
2025	11	13	6	42	15	27.68	94.4	7.1652	66.195
2025	11	13	6	52	15	25.98	94.4	7.1652	62.1178
2025	11	13	7	2	15	26.38	94.6	7.1713	63.1333
2025	11	13	7	12	15	26.34	95.9	7.1713	62.8932
2025	11	13	7	22	15	25.98	94.4	7.1713	62.173
2025	11	13	7	32	15	25.72	95.6	7.1652	61.3983
2025	11	13	7	42	15	26.82	95.3	7.1713	64.0934
2025	11	13	7	52	15	26.77	94.1	7.1652	64.0365

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	13	8	2	15	25.58	96.7	7.1652	60.9186
2025	11	13	8	12	15	25.66	93.8	7.1652	61.3982
2025	11	13	8	22	15	26.46	93.9	7.1652	63.3169
2025	11	13	8	32	15	26.01	95.3	7.1652	62.1177
2025	11	13	8	42	15	25.02	92.3	7.1591	59.9058
2025	11	13	8	52	15	25.65	93.6	7.1652	61.3982
2025	11	13	9	2	15	26.59	94.7	7.1713	63.6132
2025	11	13	9	12	15	25.58	94.5	7.1713	61.2127
2025	11	13	9	22	15	25.54	93.4	7.1713	61.2127
2025	11	13	9	32	15	26.63	95.6	7.1713	63.6132
2025	11	13	9	42	15	23.5	91	7.1713	56.4116
2025	11	13	9	52	15	24.83	93	7.1591	59.4264
2025	11	13	10	2	15	25.29	94.8	7.1652	60.4387
2025	11	13	10	12	15	24.92	95.5	7.1652	59.4794
2025	11	13	10	22	15	25.79	94.7	7.1652	61.6379
2025	11	13	10	32	15	26.29	94.8	7.1652	62.837
2025	11	13	10	42	15	25.5	95	7.1713	60.9726
2025	11	13	10	52	15	25.24	93.2	7.1713	60.4925
2025	11	13	11	2	15	24.91	95.3	7.1774	59.5851
2025	11	13	11	12	15	25.79	94.7	7.1713	61.6926
2025	11	13	11	22	15	26.31	95.2	7.1652	62.8369
2025	11	13	11	32	15	25.51	95.4	7.1652	60.9182
2025	11	13	11	42	15	24.97	94.4	7.1652	59.719
2025	11	13	11	52	15	26.16	93.7	7.1713	62.6527
2025	11	13	12	2	15	25.56	94	7.1713	61.2124
2025	11	13	12	12	15	26.08	94.6	7.1652	62.3571
2025	11	13	12	22	15	25.06	93.9	7.1713	60.0121
2025	11	13	12	32	15	25.36	93.8	7.1774	60.7862
2025	11	13	12	42	15	24.83	95.8	7.1713	59.292
2025	11	13	12	52	15	24.83	93	7.1713	59.5321
2025	11	13	13	2	15	24.94	93.2	7.1713	59.7721
2025	11	13	13	12	15	27.11	95.1	7.1652	64.7555
2025	11	13	13	22	15	24.45	93.5	7.1713	58.5719
2025	11	13	13	32	15	25.77	94.2	7.1713	61.6925
2025	11	13	13	42	15	25.82	95.6	7.1652	61.6377
2025	11	13	13	52	15	24.27	94.3	7.1713	58.0918
2025	11	13	14	2	15	25.31	91.8	7.1591	60.6243
2025	11	13	14	12	15	25.23	92.7	7.1652	60.4385
2025	11	13	14	22	15	26.08	94.4	7.1774	62.4681
2025	11	13	14	32	15	24.88	94.6	7.1774	59.585
2025	11	13	14	42	15	22.91	92	7.1774	55.02
2025	11	13	14	52	15	22.7	91	7.1835	54.5879
2025	11	13	15	2	15	25.72	95.6	7.1652	61.3978
2025	11	13	15	12	15	25.32	95.7	7.1774	60.546
2025	11	13	15	22	15	26.18	94.6	7.1774	62.7084
2025	11	13	15	32	15	25.41	95.4	7.1652	60.6783
2025	11	13	15	42	15	24.79	94.9	7.1713	59.292
2025	11	13	15	52	15	25	95	7.1652	59.7189

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	13	16	2	15	25.86	93.8	7.153	61.7673
2025	11	13	16	12	15	25.65	93.6	7.1713	61.4524
2025	11	13	16	22	15	25.93	95.8	7.1713	61.9325
2025	11	13	16	32	15	25.79	94.9	7.1713	61.6924
2025	11	13	16	42	15	25.29	94.8	7.1652	60.4384
2025	11	13	16	52	15	25.19	94.8	7.1713	60.2521
2025	11	13	17	2	15	26.26	93.9	7.1713	62.8927
2025	11	13	17	12	15	26.19	94.8	7.1713	62.6526
2025	11	13	17	22	15	25.56	94	7.1652	61.1579
2025	11	13	17	32	15	25.71	95.4	7.1713	61.4524
2025	11	13	17	42	15	25.64	93.1	7.1713	61.4524
2025	11	13	17	52	15	26.19	94.8	7.1652	62.5969
2025	11	13	18	2	15	25.36	93.8	7.1713	60.7322
2025	11	13	18	12	15	25.12	95.7	7.1713	60.0121
2025	11	13	18	22	15	25.64	93.1	7.1652	61.3977
2025	11	13	18	32	15	25.47	94.3	7.1652	60.9181
2025	11	13	18	42	15	26.38	94.3	7.1713	63.1327
2025	11	13	18	52	15	26.76	96.2	7.1713	63.8529
2025	11	13	19	2	15	25.28	94.5	7.1713	60.4922
2025	11	13	19	12	15	26.22	95.5	7.1652	62.5969
2025	11	13	19	22	15	25.95	93.5	7.1652	62.1172
2025	11	13	19	32	15	25.83	92.7	7.1713	61.9325
2025	11	13	19	42	15	25.54	93.4	7.1652	61.1579
2025	11	13	19	52	15	24.9	95.1	7.1652	59.4791
2025	11	13	20	2	15	25.69	94.9	7.1652	61.3978
2025	11	13	20	12	15	24.78	97	7.1652	58.9994
2025	11	13	20	22	15	25.24	93.4	7.1652	60.4384
2025	11	13	20	32	15	25.78	96.7	7.1713	61.4524
2025	11	13	20	42	15	25	95	7.1713	59.7721
2025	11	13	20	52	15	25.62	95.6	7.1652	61.1579
2025	11	13	21	2	15	25.94	93.1	7.1652	62.1173
2025	11	13	21	12	15	25.67	94.2	7.1713	61.4524
2025	11	13	21	22	15	25.33	95.9	7.1713	60.4922
2025	11	13	21	32	15	25.15	93.6	7.1652	60.1986
2025	11	13	21	42	15	25.21	91.8	7.1713	60.4922
2025	11	13	21	52	15	25.88	94.4	7.1652	61.8775
2025	11	13	22	2	15	25.99	94.9	7.1652	62.1173
2025	11	13	22	12	15	24.42	92.6	7.1652	58.5198
2025	11	13	22	22	15	25.51	91.6	7.1774	61.2668
2025	11	13	22	32	15	26.9	94.9	7.1652	64.2758
2025	11	13	22	42	15	24.65	93.7	7.1774	59.1044
2025	11	13	22	52	15	24.9	95.1	7.1713	59.532
2025	11	13	23	2	15	25.37	94.3	7.1713	60.7322
2025	11	13	23	12	15	26.08	94.4	7.1774	62.4681
2025	11	13	23	22	15	24.6	97.2	7.1652	58.5197
2025	11	13	23	32	15	25.36	93.8	7.1774	60.7862
2025	11	13	23	42	15	24.81	95.3	7.1774	59.3447
2025	11	13	23	52	15	25.23	92.7	7.1774	60.546

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	14	0	2	15	24.42	92.6	7.1713	58.5718
2025	11	14	0	12	15	25.72	92.5	7.1713	61.6924
2025	11	14	0	22	15	23.23	93	7.1835	55.7902
2025	11	14	0	32	15	24.95	93.7	7.1713	59.772
2025	11	14	0	42	15	24.76	93.9	7.1713	59.2919
2025	11	14	0	52	15	26.65	93.7	7.1835	63.9663
2025	11	14	1	2	15	24.34	93.3	7.1774	58.3836
2025	11	14	1	12	15	24.63	95.8	7.1713	58.8118
2025	11	14	1	22	15	24.78	94.6	7.1713	59.2919
2025	11	14	1	32	15	25.49	94.7	7.1774	61.0264
2025	11	14	1	42	15	24.63	93	7.1774	59.1043
2025	11	14	1	52	15	25.19	94.8	7.1774	60.3056
2025	11	14	2	2	15	25.85	96.2	7.1835	61.8021
2025	11	14	2	12	15	24.67	94.4	7.1774	59.1043
2025	11	14	2	22	15	24.87	94.4	7.1713	59.5319
2025	11	14	2	32	15	25.02	95.5	7.1835	59.8782
2025	11	14	2	42	15	23.85	93.8	7.1774	57.1822
2025	11	14	2	52	15	25.37	94.3	7.1774	60.7861
2025	11	14	3	2	15	24.26	94	7.1774	58.1433
2025	11	14	3	12	15	25.35	93.6	7.1774	60.7861
2025	11	14	3	22	15	26.22	92.2	7.1713	62.8926
2025	11	14	3	32	15	25.91	91.8	7.1652	62.1171
2025	11	14	3	42	15	25.81	95.3	7.1774	61.7472
2025	11	14	3	52	15	25.6	95.2	7.1774	61.2666
2025	11	14	4	2	15	24.63	95.8	7.1835	58.9163
2025	11	14	4	12	15	26.3	95	7.1774	62.9485
2025	11	14	4	22	15	26.65	93.4	7.1835	63.9663
2025	11	14	4	32	15	26.18	94.6	7.1835	62.7639
2025	11	14	4	42	15	24.94	93.2	7.1774	59.825
2025	11	14	4	52	15	25.56	94	7.1774	61.2666
2025	11	14	5	2	15	24.59	94.9	7.1774	58.864
2025	11	14	5	12	15	26.54	95.8	7.1652	63.3163
2025	11	14	5	22	15	24.62	92.1	7.1713	59.0517
2025	11	14	5	32	15	24.94	96	7.1774	59.5848
2025	11	14	5	42	15	25.43	92.9	7.1713	60.9721
2025	11	14	5	52	15	25.26	94.1	7.1774	60.5458
2025	11	14	6	2	15	25.58	96.7	7.1774	61.0263
2025	11	14	6	12	15	26.62	95.4	7.1835	63.7257
2025	11	14	6	22	15	25.59	94.7	7.1896	61.3754
2025	11	14	6	32	15	25.63	95.8	7.1835	61.3209
2025	11	14	6	42	15	25.54	96.1	7.1835	61.0804
2025	11	14	6	52	15	26.74	95.8	7.1835	63.9661
2025	11	14	7	2	15	25.04	96	7.1896	59.9312
2025	11	14	7	12	15	26.49	94.8	7.1835	63.4851
2025	11	14	7	22	15	25.85	93.5	7.1835	62.0423
2025	11	14	7	32	15	25.11	95.3	7.1835	60.1185
2025	11	14	7	42	15	25.43	92.9	7.1896	61.1346
2025	11	14	7	52	15	26.13	95.7	7.1896	62.5787

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	14	8	2	15	26.41	97.2	7.1835	63.0042
2025	11	14	8	12	15	25.29	94.8	7.1835	60.5994
2025	11	14	8	22	15	25.91	95.3	7.1896	62.0973
2025	11	14	8	32	15	25.26	94.1	7.1835	60.5994
2025	11	14	8	42	15	25.56	93.8	7.1835	61.3208
2025	11	14	8	52	15	25.02	92.1	7.1835	60.1184
2025	11	14	9	2	15	25.71	95.4	7.1835	61.5613
2025	11	14	9	12	15	26.9	94.9	7.1835	64.4469
2025	11	14	9	22	15	25.96	94	7.1896	62.3379
2025	11	14	9	32	15	25.92	95.5	7.1835	62.0422
2025	11	14	9	42	15	24.63	93	7.1835	59.1565
2025	11	14	9	52	15	24.69	94.9	7.1774	59.104
2025	11	14	10	2	15	24.86	93.9	7.1835	59.6374
2025	11	14	10	12	15	25.88	94.4	7.1774	61.9871
2025	11	14	10	22	15	26.08	94.4	7.1896	62.5785
2025	11	14	10	32	15	24.63	93	7.1774	59.1039
2025	11	14	10	42	15	25.93	92.9	7.1774	62.2273
2025	11	14	10	52	15	24.96	93.9	7.1835	59.8778
2025	11	14	11	2	15	25	90.9	7.1774	60.065
2025	11	14	11	12	15	25.59	94.7	7.1835	61.3207
2025	11	14	11	22	15	24.71	95.3	7.1835	59.1564
2025	11	14	11	32	15	25.06	93.9	7.1835	60.1183
2025	11	14	11	42	15	26.21	91.7	7.1774	62.948
2025	11	14	11	52	15	25.62	92.5	7.1835	61.561
2025	11	14	12	2	15	25.41	95.4	7.1835	60.8396
2025	11	14	12	12	15	24.61	91.6	7.1896	59.2088
2025	11	14	12	22	15	25.16	93.9	7.1774	60.3051
2025	11	14	12	32	15	25.54	93.1	7.1835	61.3206
2025	11	14	12	42	15	25.2	95	7.1835	60.3587
2025	11	14	12	52	15	24.62	92.6	7.1835	59.1563
2025	11	14	13	2	15	25.11	91.4	7.1774	60.3051
2025	11	14	13	12	15	24.47	94.2	7.1896	58.7274
2025	11	14	13	22	15	25.13	92.7	7.1835	60.3586
2025	11	14	13	32	15	25.24	93.4	7.1835	60.5991
2025	11	14	13	42	15	24.8	90.9	7.1835	59.6372
2025	11	14	13	52	15	25.65	93.6	7.1896	61.6156
2025	11	14	14	2	15	24.74	93.2	7.1835	59.3967
2025	11	14	14	12	15	25.67	94.2	7.1835	61.561
2025	11	14	14	22	15	25.59	94.9	7.1835	61.3205
2025	11	14	14	32	15	26.58	94.3	7.1835	63.7252
2025	11	14	14	42	15	25.23	95.9	7.1774	60.305
2025	11	14	14	52	15	26.48	94.5	7.1835	63.4848
2025	11	14	15	2	15	26.17	94.2	7.1835	62.7633
2025	11	14	15	12	15	24.79	94.9	7.1774	59.344
2025	11	14	15	22	15	25.53	92.9	7.1835	61.3205
2025	11	14	15	32	15	26.12	95.5	7.1835	62.5229
2025	11	14	15	42	15	25.73	92.9	7.1835	61.8015
2025	11	14	15	52	15	26.89	94.7	7.1835	64.4467

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	14	16	2	15	26.96	97.9	7.1896	64.2632
2025	11	14	16	12	15	26.58	94.5	7.1896	63.7818
2025	11	14	16	22	15	26.15	96.1	7.1896	62.5784
2025	11	14	16	32	15	25.11	95.5	7.1896	60.1715
2025	11	14	16	42	15	25.15	93.6	7.1835	60.3586
2025	11	14	16	52	15	26.37	94.1	7.1896	63.3005
2025	11	14	17	2	15	27.6	94.8	7.1896	66.1887
2025	11	14	17	12	15	25.85	93.5	7.1896	62.097
2025	11	14	17	22	15	26.79	96.9	7.1896	64.0225
2025	11	14	17	32	15	26.45	93.5	7.1896	63.5411
2025	11	14	17	42	15	26.74	95.8	7.1835	63.9657
2025	11	14	17	52	15	27.44	95.9	7.1835	65.649
2025	11	14	18	2	15	27.12	95.5	7.1835	64.9276
2025	11	14	18	12	15	27.1	97	7.1835	64.6872
2025	11	14	18	22	15	26.89	96.8	7.1835	64.2062
2025	11	14	18	32	15	26.22	97.5	7.1835	62.5229
2025	11	14	18	42	15	27.02	95.3	7.1835	64.6872
2025	11	14	18	52	15	26.86	96.2	7.1835	64.2062
2025	11	14	19	2	15	26	95.1	7.1835	62.2825
2025	11	14	19	12	15	26.92	95.3	7.1835	64.4467
2025	11	14	19	22	15	27.48	96.5	7.1835	65.6491
2025	11	14	19	32	15	26.01	95.3	7.1835	62.2825
2025	11	14	19	42	15	26.48	94.3	7.1835	63.4848
2025	11	14	19	52	15	25.87	96.7	7.1835	61.8015
2025	11	14	20	2	15	27.12	95.5	7.1835	64.9277
2025	11	14	20	12	15	27.42	95.4	7.1835	65.6491
2025	11	14	20	22	15	27.83	97.4	7.1835	66.3705
2025	11	14	20	32	15	25.92	95.5	7.1774	61.9869
2025	11	14	20	42	15	26.7	97.1	7.1774	63.6687
2025	11	14	20	52	15	26.49	96.9	7.1774	63.1882
2025	11	14	21	2	15	25.82	95.6	7.1774	61.7467
2025	11	14	21	12	15	26.42	95.4	7.1774	63.1882
2025	11	14	21	22	15	26.76	96.2	7.1774	63.909
2025	11	14	21	32	15	27	97	7.1774	64.3895
2025	11	14	21	42	15	27.23	95.7	7.1774	65.1103
2025	11	14	21	52	15	26.86	96.2	7.1774	64.1493
2025	11	14	22	2	15	26.07	96.6	7.1774	62.2272
2025	11	14	22	12	15	27.5	96.9	7.1713	65.5326
2025	11	14	22	22	15	26.32	95.5	7.1713	62.8921
2025	11	14	22	32	15	26.35	96.1	7.1713	62.8921
2025	11	14	22	42	15	25.94	99.3	7.1713	61.4518
2025	11	14	22	52	15	26.1	95.1	7.1713	62.412
2025	11	14	23	2	15	26.07	96.6	7.1713	62.172
2025	11	14	23	12	15	26.42	97.4	7.1713	62.8921
2025	11	14	23	22	15	25.69	96.9	7.1652	61.1573
2025	11	14	23	32	15	26.28	94.4	7.1652	62.8362
2025	11	14	23	42	15	27.94	95.8	7.1652	66.6735
2025	11	14	23	52	15	25.72	95.6	7.1591	61.3426

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	15	0	2	15	26.02	95.5	7.153	62.0061
2025	11	15	0	12	15	26.68	94.5	7.153	63.682
2025	11	15	0	22	15	26.51	95.2	7.147	63.1468
2025	11	15	0	32	15	26.55	93.7	7.147	63.386
2025	11	15	0	42	15	26.8	94.9	7.147	63.8644
2025	11	15	0	52	15	26.54	95.8	7.1409	63.0905
2025	11	15	1	2	15	25.57	94.3	7.1409	60.9396
2025	11	15	1	12	15	25.39	97	7.1409	60.2227
2025	11	15	1	22	15	25.59	97	7.1409	60.7007
2025	11	15	1	32	15	25.98	94.6	7.1409	61.8956
2025	11	15	1	42	15	26.74	95.8	7.1409	63.5684
2025	11	15	1	52	15	26.04	96	7.1409	61.8955
2025	11	15	2	2	15	26.48	94.5	7.1409	63.0904
2025	11	15	2	12	15	25.83	92.9	7.1409	61.6566
2025	11	15	2	22	15	26.53	95.6	7.1409	63.0904
2025	11	15	2	32	15	26.38	96.7	7.1409	62.6125
2025	11	15	2	42	15	26.86	96.2	7.1409	63.8074
2025	11	15	2	52	15	27	97	7.1409	64.0463
2025	11	15	3	2	15	25.41	95.4	7.1409	60.4616
2025	11	15	3	12	15	25.92	95.5	7.1409	61.6565
2025	11	15	3	22	15	26.03	95.7	7.1409	61.8955
2025	11	15	3	32	15	24.89	94.8	7.1409	59.2667
2025	11	15	3	42	15	24.84	96	7.1409	59.0277
2025	11	15	3	52	15	25.66	96.5	7.1409	60.9396
2025	11	15	4	2	15	26.47	98.3	7.1409	62.6124
2025	11	15	4	12	15	24.08	94.5	7.1409	57.3549
2025	11	15	4	22	15	26.22	95.5	7.1348	62.3177
2025	11	15	4	32	15	26.11	97.3	7.1348	61.8402
2025	11	15	4	42	15	26.41	95.2	7.1348	62.7952
2025	11	15	4	52	15	26	95.1	7.1348	61.8402
2025	11	15	5	2	15	27.35	96.1	7.1348	64.9441
2025	11	15	5	12	15	25.46	94.1	7.1348	60.6463
2025	11	15	5	22	15	25.64	96	7.1287	60.8307
2025	11	15	5	32	15	25.98	94.6	7.1287	61.7849
2025	11	15	5	42	15	26.18	96.8	7.1287	62.0234
2025	11	15	5	52	15	25.33	95.9	7.1287	60.115
2025	11	15	6	2	15	25.5	95.2	7.1287	60.5921
2025	11	15	6	12	15	25.69	94.7	7.1287	61.0692
2025	11	15	6	22	15	25.92	97.5	7.1287	61.3077
2025	11	15	6	32	15	25.76	94	7.1287	61.3077
2025	11	15	6	42	15	25.69	96.9	7.1287	60.8306
2025	11	15	6	52	15	26.61	97.1	7.1287	62.9776
2025	11	15	7	2	15	25.63	95.8	7.1287	60.8306
2025	11	15	7	12	15	23.87	94.3	7.1226	56.7244
2025	11	15	7	22	15	26.92	95.3	7.1226	63.8746
2025	11	15	7	32	15	26.27	96.6	7.1226	62.2062
2025	11	15	7	42	15	26.08	94.6	7.1226	61.9678
2025	11	15	7	52	15	25.92	95.5	7.1226	61.4912

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	15	8	2	15	26.16	93.7	7.1226	62.2062
2025	11	15	8	12	15	25.87	96.7	7.1226	61.2528
2025	11	15	8	22	15	26.18	96.8	7.1226	61.9678
2025	11	15	8	32	15	25.89	96.9	7.1226	61.2528
2025	11	15	8	42	15	27.23	95.7	7.1226	64.5895
2025	11	15	8	52	15	26.55	96.1	7.1226	62.9211
2025	11	15	9	2	15	27.02	95.3	7.1226	64.1128
2025	11	15	9	12	15	26.24	95.9	7.1165	62.1504
2025	11	15	9	22	15	26.83	97.5	7.1165	63.341
2025	11	15	9	32	15	25.96	96.4	7.1165	61.436
2025	11	15	9	42	15	25.5	95	7.1165	60.4835
2025	11	15	9	52	15	25.23	95.9	7.1104	59.7156
2025	11	15	10	2	15	25.62	95.6	7.1104	60.6672
2025	11	15	10	12	15	26.1	95.1	7.1104	61.8568
2025	11	15	10	22	15	26.8	94.9	7.1104	63.5221
2025	11	15	10	32	15	26.05	96.2	7.1104	61.6188
2025	11	15	10	42	15	26.15	96.1	7.1104	61.8567
2025	11	15	10	52	15	24.84	93.2	7.1104	59.0018
2025	11	15	11	2	15	25.68	94.5	7.1043	60.8505
2025	11	15	11	12	15	26.28	98.3	7.1043	61.8012
2025	11	15	11	22	15	24.4	95.2	7.1043	57.7604
2025	11	15	11	32	15	26.3	97	7.0982	61.9832
2025	11	15	11	42	15	24.78	97	7.0921	58.3685
2025	11	15	11	52	15	24.87	96.7	7.0921	58.6058
2025	11	15	12	2	15	26.42	95.4	7.086	62.346
2025	11	15	12	12	15	25.53	95.8	7.086	60.2125
2025	11	15	12	22	15	25.2	97.3	7.086	59.2642
2025	11	15	12	32	15	24.96	96.4	7.0799	58.7372
2025	11	15	12	42	15	26.26	93.9	7.0799	62.053
2025	11	15	12	52	15	23.82	92.4	7.0799	56.3688
2025	11	15	13	2	15	26.46	93.9	7.0799	62.5267
2025	11	15	13	12	15	24.63	92.8	7.0799	58.2635
2025	11	15	13	22	15	25.21	95.2	7.0799	59.4477
2025	11	15	13	32	15	25.09	97.1	7.0799	58.974
2025	11	15	13	42	15	25.31	95.4	7.0799	59.6846
2025	11	15	13	52	15	25.68	98.5	7.086	60.2124
2025	11	15	14	2	15	23.87	94.3	7.0921	56.4703
2025	11	15	14	12	15	24.71	95.3	7.0982	58.4209
2025	11	15	14	22	15	24.44	96.1	7.0982	57.7085
2025	11	15	14	32	15	24.6	95.1	7.1104	58.288
2025	11	15	14	42	15	25.23	92.7	7.1165	60.0072
2025	11	15	14	52	15	25.36	93.8	7.1165	60.2453
2025	11	15	15	2	15	25.82	95.6	7.1165	61.1978
2025	11	15	15	12	15	26.62	95.4	7.1226	63.1593
2025	11	15	15	22	15	25.4	95	7.1226	60.2993
2025	11	15	15	32	15	25.79	94.7	7.1226	61.2526
2025	11	15	15	42	15	25.18	94.6	7.1287	59.8762
2025	11	15	15	52	15	25.47	96.5	7.1287	60.3533

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	15	16	2	15	24.65	96.3	7.1348	58.4971
2025	11	15	16	12	15	26.39	94.8	7.1348	62.7949
2025	11	15	16	22	15	25.73	92.7	7.1409	61.4172
2025	11	15	16	32	15	25.13	93	7.1409	59.9833
2025	11	15	16	42	15	25.72	95.6	7.147	61.2328
2025	11	15	16	52	15	26.26	93.7	7.147	62.6679
2025	11	15	17	2	15	27.3	94.8	7.153	65.1179
2025	11	15	17	12	15	25.3	95	7.1652	60.4374
2025	11	15	17	22	15	26.28	98.3	7.1774	62.467
2025	11	15	17	32	15	26.83	97.5	7.1835	63.9653
2025	11	15	17	42	15	26.02	95.5	7.1835	62.282
2025	11	15	17	52	15	24.82	95.5	7.1896	59.4491
2025	11	15	18	2	15	26.76	96.2	7.1896	64.0221
2025	11	15	18	12	15	26.59	94.7	7.1957	63.838
2025	11	15	18	22	15	26.65	96	7.1957	63.838
2025	11	15	18	32	15	26.61	95.2	7.2018	63.8946
2025	11	15	18	42	15	24.79	94.9	7.2018	59.5545
2025	11	15	18	52	15	26.06	94	7.2079	62.7445
2025	11	15	19	2	15	27.27	96.3	7.2079	65.3991
2025	11	15	19	12	15	26.62	95.4	7.214	64.0077
2025	11	15	19	22	15	26	95.1	7.214	62.5585
2025	11	15	19	32	15	26.08	94.4	7.2201	62.8555
2025	11	15	19	42	15	24.76	93.9	7.2262	59.7655
2025	11	15	19	52	15	27.07	94.2	7.2384	65.4459
2025	11	15	20	2	15	27.18	94.4	7.2445	65.7462
2025	11	15	20	12	15	26.24	93.3	7.2506	63.6187
2025	11	15	20	22	15	26.08	94.6	7.2567	63.1885
2025	11	15	20	32	15	26.22	95.5	7.2628	63.4873
2025	11	15	20	42	15	26.49	96.9	7.2628	63.9738
2025	11	15	20	52	15	26.12	97.5	7.2628	63.0008
2025	11	15	21	2	15	26.21	95.3	7.2689	63.543
2025	11	15	21	12	15	26.52	95.4	7.2689	64.2734
2025	11	15	21	22	15	25.82	95.6	7.2689	62.5692
2025	11	15	21	32	15	26.28	94.6	7.2689	63.7865
2025	11	15	21	42	15	26.94	95.8	7.2689	65.2473
2025	11	15	21	52	15	27.9	96.8	7.2689	67.4384
2025	11	15	22	2	15	27.01	97.2	7.275	65.3045
2025	11	15	22	12	15	26.35	96.1	7.275	63.8424
2025	11	15	22	22	15	26.77	94.3	7.2811	65.1178
2025	11	15	22	32	15	26.59	96.9	7.2811	64.3862
2025	11	15	22	42	15	27.01	97.2	7.2811	65.3617
2025	11	15	22	52	15	27.03	92.5	7.2811	65.8495
2025	11	15	23	2	15	27.99	94.5	7.2872	68.104
2025	11	15	23	12	15	27.68	94.4	7.2872	67.3717
2025	11	15	23	22	15	27.01	97.2	7.2872	65.4189
2025	11	15	23	32	15	26.24	95.9	7.2872	63.7102
2025	11	15	23	42	15	25.55	96.3	7.2872	62.0015
2025	11	15	23	52	15	26.26	93.9	7.2872	63.9543

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	16	0	2	15	27.11	97.2	7.2994	65.7779
2025	11	16	0	12	15	27.45	97.7	7.3054	66.5696
2025	11	16	0	22	15	25.91	95.3	7.3115	63.1983
2025	11	16	0	32	15	26.76	96.2	7.3176	65.2148
2025	11	16	0	42	15	26.12	95.5	7.3176	63.7437
2025	11	16	0	52	15	26.08	96.8	7.3237	63.5539
2025	11	16	1	2	15	26.65	93.7	7.3176	65.2148
2025	11	16	1	12	15	25.64	93.4	7.3176	62.7631
2025	11	16	1	22	15	26.92	95.3	7.3176	65.7051
2025	11	16	1	32	15	27	94.9	7.3176	65.9503
2025	11	16	1	42	15	25.66	93.8	7.3176	62.7631
2025	11	16	1	52	15	27.25	96.1	7.3176	66.4406
2025	11	16	2	2	15	26.77	94.3	7.3176	65.46
2025	11	16	2	12	15	26.93	95.5	7.3237	65.7624
2025	11	16	2	22	15	26.72	95.4	7.3237	65.2716
2025	11	16	2	32	15	26.1	95.1	7.3176	63.7438
2025	11	16	2	42	15	25.74	93.3	7.3176	63.0083
2025	11	16	2	52	15	26.08	94.6	7.3115	63.6883
2025	11	16	3	2	15	26.44	95.9	7.3176	64.4793
2025	11	16	3	12	15	26.96	96.2	7.3115	65.6479
2025	11	16	3	22	15	26.13	95.7	7.3115	63.6883
2025	11	16	3	32	15	26.47	94.1	7.3115	64.6681
2025	11	16	3	42	15	26.86	96.2	7.3115	65.403
2025	11	16	3	52	15	26.18	96.8	7.3176	63.7438
2025	11	16	4	2	15	26.8	94.9	7.3115	65.403
2025	11	16	4	12	15	25.52	95.6	7.3115	62.2186
2025	11	16	4	22	15	26.53	95.6	7.3115	64.6682
2025	11	16	4	32	15	25.61	95.4	7.2994	62.3547
2025	11	16	4	42	15	24.85	96.2	7.3054	60.4512
2025	11	16	4	52	15	25.33	95.9	7.2994	61.6211
2025	11	16	5	2	15	25.69	94.7	7.3054	62.6539
2025	11	16	5	12	15	25.43	92.9	7.3054	62.1644
2025	11	16	5	22	15	26.06	93.7	7.2994	63.5773
2025	11	16	5	32	15	25.01	95.3	7.3054	60.9407
2025	11	16	5	42	15	25.61	95.4	7.2994	62.3547
2025	11	16	5	52	15	26.22	95.5	7.2994	63.8219
2025	11	16	6	2	15	26.33	95.7	7.2994	64.0664
2025	11	16	6	12	15	26.15	93.5	7.2994	63.8219
2025	11	16	6	22	15	26.31	97.2	7.2994	63.8219
2025	11	16	6	32	15	25.62	95.6	7.2933	62.3003
2025	11	16	6	42	15	26.38	94.6	7.2994	64.311
2025	11	16	6	52	15	26.47	94.1	7.2933	64.4991
2025	11	16	7	2	15	26.44	93.3	7.2933	64.4991
2025	11	16	7	12	15	25.64	96	7.2933	62.3003
2025	11	16	7	22	15	25.83	95.8	7.2872	62.7341
2025	11	16	7	32	15	24.87	94.4	7.2811	60.4842
2025	11	16	7	42	15	27.08	98.3	7.2933	65.4764
2025	11	16	7	52	15	26.66	96.2	7.2872	64.6869

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	16	8	2	15	25.69	94.9	7.2811	62.4353
2025	11	16	8	12	15	25.8	95.1	7.2872	62.7341
2025	11	16	8	22	15	26.28	94.6	7.2933	64.0105
2025	11	16	8	32	15	25.16	93.9	7.2811	61.2159
2025	11	16	8	42	15	26.92	95.3	7.2872	65.4192
2025	11	16	8	52	15	26.04	93.1	7.2811	63.4109
2025	11	16	9	2	15	25.26	96.4	7.2811	61.2159
2025	11	16	9	12	15	25.53	95.8	7.2811	61.9476
2025	11	16	9	22	15	24.77	94.2	7.2811	60.2403
2025	11	16	9	32	15	26.52	95.4	7.275	64.3301
2025	11	16	9	42	15	25.42	95.6	7.275	61.6497
2025	11	16	9	52	15	26.95	93.4	7.275	65.5485
2025	11	16	10	2	15	24.23	95.9	7.275	58.7256
2025	11	16	10	12	15	25.89	96.9	7.275	62.6244
2025	11	16	10	22	15	26.12	95.5	7.275	63.3554
2025	11	16	10	32	15	25.61	97.4	7.2689	61.8391
2025	11	16	10	42	15	26.13	95.7	7.2689	63.2999
2025	11	16	10	52	15	25.64	93.4	7.2689	62.326
2025	11	16	11	2	15	25.66	94	7.2689	62.326
2025	11	16	11	12	15	25.89	94.7	7.2689	62.813
2025	11	16	11	22	15	25.13	93	7.2689	61.1087
2025	11	16	11	32	15	25.57	94.3	7.2689	62.0826
2025	11	16	11	42	15	25.82	97.6	7.2689	62.326
2025	11	16	11	52	15	26.1	95.1	7.2689	63.2999
2025	11	16	12	2	15	25.58	96.7	7.2689	61.8391
2025	11	16	12	12	15	24.77	94.2	7.2628	60.0821
2025	11	16	12	22	15	25.69	94.9	7.2689	62.326
2025	11	16	12	32	15	24.39	94.9	7.2567	59.0573
2025	11	16	12	42	15	25.56	93.8	7.2689	62.0826
2025	11	16	12	52	15	25.96	93.8	7.2628	63.0011
2025	11	16	13	2	15	25.19	94.8	7.2628	61.0552
2025	11	16	13	12	15	25.28	96.8	7.2689	61.1087
2025	11	16	13	22	15	25.23	93	7.2567	61.2446
2025	11	16	13	32	15	25.87	94.2	7.2628	62.7579
2025	11	16	13	42	15	25.24	96.1	7.2689	61.1087
2025	11	16	13	52	15	24.95	93.4	7.2567	60.5155
2025	11	16	14	2	15	26.68	94.5	7.2628	64.7038
2025	11	16	14	12	15	25.16	94.1	7.2628	61.055
2025	11	16	14	22	15	24.03	92.6	7.2628	58.3793
2025	11	16	14	32	15	24.24	93.3	7.2506	58.7625
2025	11	16	14	42	15	25.12	92.3	7.2628	61.0551
2025	11	16	14	52	15	24.76	93.9	7.2567	60.0293
2025	11	16	15	2	15	24.87	94.4	7.2567	60.2724
2025	11	16	15	12	15	24.77	94.2	7.2689	60.1348
2025	11	16	15	22	15	25.19	94.8	7.2628	61.0551
2025	11	16	15	32	15	24.79	94.9	7.2628	60.0821
2025	11	16	15	42	15	24.96	94.1	7.2628	60.5686
2025	11	16	15	52	15	24.7	95.1	7.2567	59.7863

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	16	16	2	15	25.34	93.2	7.2628	61.5416
2025	11	16	16	12	15	26.64	93	7.2567	64.647
2025	11	16	16	22	15	26.07	96.6	7.2628	63.0011
2025	11	16	16	32	15	25.3	95.2	7.2628	61.2984
2025	11	16	16	42	15	25.76	96.5	7.2628	62.2713
2025	11	16	16	52	15	25.1	95	7.2628	60.8119
2025	11	16	17	2	15	26.35	93.5	7.2628	63.9741
2025	11	16	17	12	15	24.92	95.5	7.2628	60.3254
2025	11	16	17	22	15	26.38	94.6	7.2689	64.0303
2025	11	16	17	32	15	25.02	92.1	7.2689	60.8653
2025	11	16	17	42	15	26.77	94.3	7.2628	64.9471
2025	11	16	17	52	15	25.04	93.2	7.2628	60.8119
2025	11	16	18	2	15	24.24	93.3	7.2628	58.8659
2025	11	16	18	12	15	26.65	93.7	7.2628	64.7039
2025	11	16	18	22	15	26.55	93.7	7.2628	64.4606
2025	11	16	18	32	15	25.96	94	7.2628	63.0012
2025	11	16	18	42	15	26.13	95.7	7.2628	63.2444
2025	11	16	18	52	15	26.19	94.8	7.2628	63.4877
2025	11	16	19	2	15	25.96	94	7.2628	63.0012
2025	11	16	19	12	15	26.41	95.2	7.2628	63.9742
2025	11	16	19	22	15	25.69	94.9	7.2628	62.2715
2025	11	16	19	32	15	24.69	94.9	7.2628	59.839
2025	11	16	19	42	15	25.69	94.7	7.2628	62.2715
2025	11	16	19	52	15	24.92	92.3	7.2628	60.5688
2025	11	16	20	2	15	26.54	93.2	7.2628	64.4608
2025	11	16	20	12	15	26.04	93.3	7.2628	63.2445
2025	11	16	20	22	15	25.9	95.1	7.2628	62.758
2025	11	16	20	32	15	26.79	94.7	7.2689	65.0043
2025	11	16	20	42	15	25.2	95	7.2628	61.0553
2025	11	16	20	52	15	25.66	93.8	7.2628	62.2716
2025	11	16	21	2	15	25.84	93.1	7.2628	62.7581
2025	11	16	21	12	15	26.53	92.8	7.2628	64.4608
2025	11	16	21	22	15	25.24	93.4	7.2689	61.3524
2025	11	16	21	32	15	24.86	93.9	7.2689	60.3786
2025	11	16	21	42	15	24.43	93	7.2689	59.4048
2025	11	16	21	52	15	26.4	95	7.2689	64.0306
2025	11	16	22	2	15	24.63	93	7.2689	59.8917
2025	11	16	22	12	15	25.24	93.4	7.2689	61.3525
2025	11	16	22	22	15	25.96	93.8	7.2689	63.0567
2025	11	16	22	32	15	25.78	98.5	7.2689	62.0829
2025	11	16	22	42	15	24.12	92.1	7.2689	58.6745
2025	11	16	22	52	15	25.12	92.1	7.2689	61.1091
2025	11	16	23	2	15	24.51	91.4	7.2689	59.6483
2025	11	16	23	12	15	24.51	91.9	7.2689	59.6484
2025	11	16	23	22	15	26.92	95.3	7.2689	65.248
2025	11	16	23	32	15	24.62	92.1	7.2689	59.8919
2025	11	16	23	42	15	25.54	93.4	7.2689	62.083
2025	11	16	23	52	15	23.75	93.6	7.2689	57.7007

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	17	0	2	15	26.38	94.6	7.2689	64.0308
2025	11	17	0	12	15	25.23	95.9	7.2689	61.1093
2025	11	17	0	22	15	25.92	95.5	7.2689	62.8135
2025	11	17	0	32	15	26.82	95.3	7.2689	65.0047
2025	11	17	0	42	15	25.84	93.1	7.2689	62.8135
2025	11	17	0	52	15	26.27	94.1	7.2689	63.7874
2025	11	17	1	2	15	25.33	92.9	7.2689	61.5963
2025	11	17	1	12	15	25.83	95.8	7.2689	62.5701
2025	11	17	1	22	15	26.67	96.5	7.275	64.5744
2025	11	17	1	32	15	26.9	94.9	7.2689	65.2482
2025	11	17	1	42	15	27.22	95.5	7.275	66.0365
2025	11	17	1	52	15	25.76	94	7.275	62.625
2025	11	17	2	2	15	25.84	93.3	7.275	62.8687
2025	11	17	2	12	15	25.05	96.2	7.2689	60.6225
2025	11	17	2	22	15	26.65	93.7	7.2689	64.7614
2025	11	17	2	32	15	25.43	92.7	7.275	61.894
2025	11	17	2	42	15	25.31	91.8	7.275	61.6504
2025	11	17	2	52	15	25.21	91.8	7.275	61.4067
2025	11	17	3	2	15	25.43	95.9	7.275	61.6504
2025	11	17	3	12	15	24.64	93.3	7.275	59.9447
2025	11	17	3	22	15	25.77	94.2	7.275	62.6251
2025	11	17	3	32	15	25.38	94.5	7.275	61.6504
2025	11	17	3	42	15	26.08	94.4	7.275	63.3562
2025	11	17	3	52	15	26.42	95.4	7.275	64.0872
2025	11	17	4	2	15	25.32	95.7	7.275	61.4068
2025	11	17	4	12	15	25.65	93.6	7.275	62.3815
2025	11	17	4	22	15	25.71	91.8	7.275	62.6252
2025	11	17	4	32	15	26.55	93.7	7.275	64.5746
2025	11	17	4	42	15	25.47	94.3	7.2872	62.0026
2025	11	17	4	52	15	25.49	94.7	7.2811	61.9484
2025	11	17	5	2	15	25.26	93.9	7.275	61.4068
2025	11	17	5	12	15	24.84	93.2	7.2811	60.4851
2025	11	17	5	22	15	24.9	90.9	7.2811	60.729
2025	11	17	5	32	15	26.4	90.7	7.2811	64.3874
2025	11	17	5	42	15	24.2	90.5	7.2811	59.0218
2025	11	17	5	52	15	26.15	93.5	7.2811	63.6557
2025	11	17	6	2	15	25.28	94.5	7.2811	61.4607
2025	11	17	6	12	15	25.66	93.8	7.2872	62.491
2025	11	17	6	22	15	25.59	94.7	7.2872	62.2469
2025	11	17	6	32	15	26.2	95	7.2872	63.7115
2025	11	17	6	42	15	25.22	92	7.2933	61.5684
2025	11	17	6	52	15	25.63	92.7	7.2872	62.491
2025	11	17	7	2	15	26.13	95.7	7.2872	63.4674
2025	11	17	7	12	15	26.08	94.6	7.2872	63.4674
2025	11	17	7	22	15	24.74	93.2	7.2872	60.2941
2025	11	17	7	32	15	24.69	94.9	7.2872	60.05
2025	11	17	7	42	15	26.01	91.8	7.2872	63.4675
2025	11	17	7	52	15	26.5	90.9	7.2872	64.688

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	17	8	2	15	24.65	93.7	7.2872	60.05
2025	11	17	8	12	15	25.9	95.1	7.2811	62.9242
2025	11	17	8	22	15	25.9	95.1	7.2872	62.9793
2025	11	17	8	32	15	25.61	91.8	7.2872	62.4911
2025	11	17	8	42	15	25.36	93.8	7.2872	61.7588
2025	11	17	8	52	15	23.62	92.2	7.2872	57.609
2025	11	17	9	2	15	24.51	91.2	7.2811	59.7536
2025	11	17	9	12	15	25.11	91.6	7.2811	61.217
2025	11	17	9	22	15	25.19	94.8	7.2811	61.2169
2025	11	17	9	32	15	24.69	94.9	7.2811	59.9975
2025	11	17	9	42	15	24.17	94.5	7.2811	58.778
2025	11	17	9	52	15	26.78	94.5	7.275	65.0622
2025	11	17	10	2	15	26.28	96.8	7.275	63.6001
2025	11	17	10	12	15	25.02	95.5	7.275	60.6759
2025	11	17	10	22	15	25.56	94	7.275	62.138
2025	11	17	10	32	15	25.5	95	7.275	61.8943
2025	11	17	10	42	15	25.74	93.1	7.2689	62.5705
2025	11	17	10	52	15	25.11	95.3	7.2689	60.8662
2025	11	17	11	2	15	26.38	94.3	7.2689	64.0313
2025	11	17	11	12	15	25.4	95.2	7.2689	61.5966
2025	11	17	11	22	15	23.44	93.2	7.2689	56.9708
2025	11	17	11	32	15	24.73	92.8	7.2689	60.1358
2025	11	17	11	42	15	25.3	95.2	7.2689	61.3532
2025	11	17	11	52	15	25.79	94.7	7.2689	62.5705
2025	11	17	12	2	15	24.7	90.9	7.2689	60.1358
2025	11	17	12	12	15	24.57	96.8	7.2628	59.3533
2025	11	17	12	22	15	24.16	94	7.2689	58.675
2025	11	17	12	32	15	23.51	91.7	7.2689	57.2142
2025	11	17	12	42	15	24.94	93.2	7.2628	60.5696
2025	11	17	12	52	15	23.51	91.7	7.2628	57.164
2025	11	17	13	2	15	24.88	94.6	7.2628	60.3263
2025	11	17	13	12	15	23.47	94.4	7.2689	56.9706
2025	11	17	13	22	15	24.83	92.8	7.2689	60.3791
2025	11	17	13	32	15	24.14	93.3	7.2628	58.6234
2025	11	17	13	42	15	24.43	92.8	7.2567	59.3011
2025	11	17	13	52	15	24.81	91.8	7.2628	60.3262
2025	11	17	14	2	15	25.23	92.7	7.2628	61.2992
2025	11	17	14	12	15	26.04	96	7.2628	63.002
2025	11	17	14	22	15	23.71	91.2	7.2628	57.6505
2025	11	17	14	32	15	23.97	94.3	7.2689	58.188
2025	11	17	14	42	15	24.35	93.8	7.2628	59.11
2025	11	17	14	52	15	24.85	93.5	7.2628	60.3262
2025	11	17	15	2	15	24.81	95.3	7.2567	60.0303
2025	11	17	15	12	15	25.99	94.9	7.2567	62.9467
2025	11	17	15	22	15	24.05	93.6	7.2506	58.2778
2025	11	17	15	32	15	24.7	90.9	7.2567	60.0303
2025	11	17	15	42	15	25.05	96.2	7.2567	60.5163
2025	11	17	15	52	15	24.11	91.9	7.2506	58.5206

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	17	16	2	15	24.8	90	7.2445	60.1674
2025	11	17	16	12	15	23.51	91.7	7.2506	57.0637
2025	11	17	16	22	15	24.6	90.2	7.2506	59.7347
2025	11	17	16	32	15	23.51	91.9	7.2445	57.0135
2025	11	17	16	42	15	25.54	93.4	7.2567	61.9746
2025	11	17	16	52	15	23.14	93.2	7.2506	56.0924
2025	11	17	17	2	15	24.25	93.5	7.2384	58.6601
2025	11	17	17	12	15	24.75	93.5	7.2384	59.8721
2025	11	17	17	22	15	26.02	92.2	7.2506	63.1343
2025	11	17	17	32	15	23.56	94.1	7.2384	56.9634
2025	11	17	17	42	15	23.32	92.2	7.2384	56.4786
2025	11	17	17	52	15	24.26	94	7.2506	58.7635
2025	11	17	18	2	15	25.03	93	7.2445	60.6528
2025	11	17	18	12	15	23.95	93.8	7.2506	58.0351
2025	11	17	18	22	15	24.13	92.9	7.2323	58.3664
2025	11	17	18	32	15	25.33	92.7	7.2323	61.2726
2025	11	17	18	42	15	24.85	93.5	7.2384	60.1147
2025	11	17	18	52	15	24.65	93.7	7.2384	59.6299
2025	11	17	19	2	15	24.92	92.5	7.2384	60.3571
2025	11	17	19	12	15	24.56	94	7.2201	59.2306
2025	11	17	19	22	15	25.24	93.2	7.2323	61.0305
2025	11	17	19	32	15	25.62	92.5	7.2262	61.9446
2025	11	17	19	42	15	24.73	92.8	7.2323	59.8196
2025	11	17	19	52	15	25	90	7.2323	60.5462
2025	11	17	20	2	15	24.89	94.8	7.2323	60.0618
2025	11	17	20	12	15	25.66	96.5	7.2323	61.7571
2025	11	17	20	22	15	27	94.9	7.2323	65.1477
2025	11	17	20	32	15	25.15	93.6	7.2323	60.7884
2025	11	17	20	42	15	25.11	95.3	7.2384	60.5996
2025	11	17	20	52	15	26.02	92	7.2323	62.9681
2025	11	17	21	2	15	24.88	94.6	7.2384	60.1148
2025	11	17	21	12	15	25.15	93.6	7.2384	60.842
2025	11	17	21	22	15	25.92	92	7.2445	62.8365
2025	11	17	21	32	15	25.44	93.2	7.2445	61.6235
2025	11	17	21	42	15	25.58	94.5	7.2506	61.9205
2025	11	17	21	52	15	25.01	91.8	7.2506	60.7064
2025	11	17	22	2	15	24.75	96.3	7.2506	59.7351
2025	11	17	22	12	15	25.46	93.8	7.2506	61.6777
2025	11	17	22	22	15	26.78	94.5	7.2506	64.8345
2025	11	17	22	32	15	25.35	93.6	7.2689	61.597
2025	11	17	22	42	15	26.48	94.3	7.2628	64.2187
2025	11	17	22	52	15	24.72	92.5	7.2689	60.1362
2025	11	17	23	2	15	26.75	93.6	7.2689	65.0055
2025	11	17	23	12	15	26.25	93.5	7.275	63.8441
2025	11	17	23	22	15	25.49	94.7	7.275	61.8947
2025	11	17	23	32	15	25.52	95.6	7.2811	61.9489
2025	11	17	23	42	15	25.26	93.9	7.2811	61.4612
2025	11	17	23	52	15	26.35	93.5	7.2872	64.2002

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	18	0	2	15	26.18	94.4	7.2872	63.7119
2025	11	18	0	12	15	24.79	94.9	7.2872	60.2944
2025	11	18	0	22	15	24.94	96	7.2811	60.4856
2025	11	18	0	32	15	24.31	91.9	7.2933	59.3699
2025	11	18	0	42	15	24.67	94.2	7.2933	60.1029
2025	11	18	0	52	15	25.86	94	7.2933	63.0347
2025	11	18	1	2	15	25.81	91.8	7.2994	63.0898
2025	11	18	1	12	15	26.43	92.8	7.3054	64.6134
2025	11	18	1	22	15	26.16	93.9	7.3054	63.8792
2025	11	18	1	32	15	25.86	96.4	7.3054	62.9002
2025	11	18	1	42	15	26.31	91.5	7.3054	64.3687
2025	11	18	1	52	15	24.74	93.2	7.3054	60.4527
2025	11	18	2	2	15	25.62	95.6	7.3054	62.4107
2025	11	18	2	12	15	25.21	91.8	7.3054	61.6764
2025	11	18	2	22	15	24.81	91.8	7.3115	60.7504
2025	11	18	2	32	15	25.66	94	7.3115	62.7101
2025	11	18	2	42	15	25.93	92.9	7.3115	63.445
2025	11	18	2	52	15	24.71	91.4	7.3115	60.5055
2025	11	18	3	2	15	25.88	94.4	7.3115	63.2001
2025	11	18	3	12	15	26.21	91.7	7.3115	64.1799
2025	11	18	3	22	15	26.71	91.7	7.3176	65.4617
2025	11	18	3	32	15	25.49	94.7	7.3176	62.2745
2025	11	18	3	42	15	26.02	92	7.3176	63.7455
2025	11	18	3	52	15	25.77	94.2	7.3176	63.01
2025	11	18	4	2	15	25.08	94.6	7.3176	61.2938
2025	11	18	4	12	15	25.92	95.5	7.3176	63.2552
2025	11	18	4	22	15	26.75	93.6	7.3115	65.4047
2025	11	18	4	32	15	24.65	93.7	7.3176	60.3131
2025	11	18	4	42	15	25.05	93.7	7.3176	61.2938
2025	11	18	4	52	15	25.24	93.2	7.3176	61.7842
2025	11	18	5	2	15	26.13	92.6	7.3176	63.9907
2025	11	18	5	12	15	25.44	93.2	7.3176	62.2745
2025	11	18	5	22	15	24.92	92.1	7.3176	61.0487
2025	11	18	5	32	15	26.08	94.4	7.3176	63.7456
2025	11	18	5	42	15	24.62	92.1	7.3176	60.3132
2025	11	18	5	52	15	25.53	92.7	7.3176	62.5197
2025	11	18	6	2	15	27.05	93.6	7.3176	66.1974
2025	11	18	6	12	15	24.91	91.8	7.3176	61.0487
2025	11	18	6	22	15	25	90.7	7.3176	61.2939
2025	11	18	6	32	15	25.61	91.8	7.3176	62.7649
2025	11	18	6	42	15	25.65	93.6	7.3176	62.7649
2025	11	18	6	52	15	25.21	91.8	7.3176	61.7843
2025	11	18	7	2	15	26.1	90.4	7.3176	63.9908
2025	11	18	7	12	15	26.04	93.1	7.3176	63.7457
2025	11	18	7	22	15	25.41	91.8	7.3176	62.2746
2025	11	18	7	32	15	25.18	94.6	7.3176	61.5391
2025	11	18	7	42	15	25.06	93.9	7.3176	61.2939
2025	11	18	7	52	15	24.95	93.7	7.3176	61.0488

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	18	8	2	15	25.55	93.6	7.3176	62.5198
2025	11	18	8	12	15	25.44	93.2	7.3176	62.2747
2025	11	18	8	22	15	26.23	92.6	7.3176	64.2361
2025	11	18	8	32	15	25.52	92.5	7.3176	62.5198
2025	11	18	8	42	15	25.01	91.8	7.3176	61.294
2025	11	18	8	52	15	25.43	92.9	7.3176	62.2747
2025	11	18	9	2	15	24.51	91.6	7.3176	60.0681
2025	11	18	9	12	15	24.8	90	7.3176	60.8036
2025	11	18	9	22	15	25.07	94.3	7.3176	61.294
2025	11	18	9	32	15	24.59	94.9	7.3176	60.0681
2025	11	18	9	42	15	24.58	94.7	7.3176	60.0681
2025	11	18	9	52	15	24.42	92.1	7.3176	59.8229
2025	11	18	10	2	15	24.17	94.5	7.3176	59.0874
2025	11	18	10	12	15	23.71	91.9	7.3176	58.1067
2025	11	18	10	22	15	25.32	95.7	7.3176	61.7843
2025	11	18	10	32	15	25.46	93.8	7.3115	62.2204
2025	11	18	10	42	15	24.76	93.9	7.3176	60.5584
2025	11	18	10	52	15	26.94	93.2	7.3176	65.9523
2025	11	18	11	2	15	24.58	94.7	7.3176	60.0681
2025	11	18	11	12	15	24.74	93.2	7.3115	60.5057
2025	11	18	11	22	15	25.64	93.4	7.3115	62.7104
2025	11	18	11	32	15	25.49	94.7	7.3115	62.2204
2025	11	18	11	42	15	24.05	93.8	7.3176	58.8422
2025	11	18	11	52	15	24.24	93.3	7.3176	59.3326
2025	11	18	12	2	15	24.21	91.9	7.3176	59.3326
2025	11	18	12	12	15	24.35	93.5	7.3176	59.5778
2025	11	18	12	22	15	24.94	93.2	7.3176	61.0488
2025	11	18	12	32	15	24.58	94.7	7.3115	60.0158
2025	11	18	12	42	15	23.51	91.9	7.3176	57.6163
2025	11	18	12	52	15	24.33	92.8	7.3115	59.5258
2025	11	18	13	2	15	24.68	94.6	7.3115	60.2607
2025	11	18	13	12	15	25.05	93.7	7.3115	61.2406
2025	11	18	13	22	15	24.44	93.3	7.3115	59.7708
2025	11	18	13	32	15	25.46	93.8	7.3115	62.2204
2025	11	18	13	42	15	23.78	94.6	7.3115	58.0561
2025	11	18	13	52	15	25.36	94.1	7.3115	61.9755
2025	11	18	14	2	15	24.75	93.7	7.3176	60.5585
2025	11	18	14	12	15	23.98	94.5	7.3115	58.546
2025	11	18	14	22	15	23.43	92.7	7.3115	57.3212
2025	11	18	14	32	15	24.52	95.6	7.3176	59.8229
2025	11	18	14	42	15	25.43	95.9	7.3176	62.0295
2025	11	18	14	52	15	24.43	95.9	7.3176	59.5778
2025	11	18	15	2	15	24.49	94.9	7.3176	59.823
2025	11	18	15	12	15	25.04	93.2	7.3176	61.294
2025	11	18	15	22	15	24.95	93.4	7.3176	61.0489
2025	11	18	15	32	15	24.95	93.7	7.3176	61.0489
2025	11	18	15	42	15	25.02	92.5	7.3237	61.3474
2025	11	18	15	52	15	25.81	91.6	7.3237	63.3105

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	18	16	2	15	25.65	93.6	7.3237	62.8197
2025	11	18	16	12	15	25.32	92.3	7.3237	62.0836
2025	11	18	16	22	15	24.63	92.8	7.3237	60.3659
2025	11	18	16	32	15	24.63	93	7.3237	60.3659
2025	11	18	16	42	15	24.57	94.2	7.3237	60.1205
2025	11	18	16	52	15	24.02	92.4	7.3237	58.8935
2025	11	18	17	2	15	23.95	93.8	7.3237	58.6482
2025	11	18	17	12	15	22.82	92.3	7.3237	55.9489
2025	11	18	17	22	15	24.65	93.7	7.3237	60.3659
2025	11	18	17	32	15	24.93	92.8	7.3237	61.1021
2025	11	18	17	42	15	24.88	94.6	7.3237	60.8567
2025	11	18	17	52	15	24.41	91.4	7.3237	59.8752
2025	11	18	18	2	15	24.43	92.8	7.3237	59.8752
2025	11	18	18	12	15	23.61	91.9	7.3237	57.9121
2025	11	18	18	22	15	25.01	95.3	7.3237	61.1021
2025	11	18	18	32	15	24.85	96.2	7.3237	60.6114
2025	11	18	18	42	15	24.57	96.8	7.3237	59.8752
2025	11	18	18	52	15	25.06	96.4	7.3237	61.1022
2025	11	18	19	2	15	25.01	95.3	7.3237	61.1022
2025	11	18	19	12	15	24.2	97.4	7.3237	58.8937
2025	11	18	19	22	15	24.23	95.9	7.3237	59.1391
2025	11	18	19	32	15	23.58	94.9	7.3237	57.6667
2025	11	18	19	42	15	24.26	94	7.3237	59.3845
2025	11	18	19	52	15	23.88	94.8	7.3237	58.4029
2025	11	18	20	2	15	25.16	94.1	7.3237	61.593
2025	11	18	20	12	15	25.4	95	7.3237	62.0838
2025	11	18	20	22	15	25.38	94.5	7.3237	62.0838
2025	11	18	20	32	15	26.14	93.3	7.3176	63.9913
2025	11	18	20	42	15	25.75	93.6	7.3176	63.0106
2025	11	18	20	52	15	23.64	93.4	7.3176	57.8618
2025	11	18	21	2	15	24.12	92.4	7.3176	59.0877
2025	11	18	21	12	15	24.62	92.3	7.3176	60.3136
2025	11	18	21	22	15	24.25	93.8	7.3176	59.3329
2025	11	18	21	32	15	24.8	90.9	7.3176	60.804
2025	11	18	21	42	15	23.73	92.7	7.3176	58.1071
2025	11	18	21	52	15	25.64	93.4	7.3176	62.7655
2025	11	18	22	2	15	24.27	94.5	7.3115	59.2813
2025	11	18	22	12	15	25.06	93.9	7.3115	61.241
2025	11	18	22	22	15	24.31	91.9	7.3115	59.5263
2025	11	18	22	32	15	24.1	91	7.3115	59.0364
2025	11	18	22	42	15	24.8	90.9	7.3115	60.7511
2025	11	18	22	52	15	23.89	95	7.3115	58.3015
2025	11	18	23	2	15	22.31	91.8	7.3115	54.627
2025	11	18	23	12	15	24.77	96.7	7.3115	60.2612
2025	11	18	23	22	15	24.65	93.7	7.3115	60.2612
2025	11	18	23	32	15	23.91	95.5	7.3115	58.3015
2025	11	18	23	42	15	23.35	93.7	7.3054	57.027
2025	11	18	23	52	15	24.8	95.1	7.3054	60.4535

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	19	0	2	15	24.48	94.7	7.3054	59.7192
2025	11	19	0	12	15	24.02	92.1	7.3054	58.7402
2025	11	19	0	22	15	24.77	96.7	7.3054	60.2087
2025	11	19	0	32	15	25.8	95.1	7.3054	62.901
2025	11	19	0	42	15	23.58	94.6	7.3054	57.5165
2025	11	19	0	52	15	25.03	95.7	7.3054	60.943
2025	11	19	1	2	15	24.37	94.2	7.2994	59.4226
2025	11	19	1	12	15	25.78	94.4	7.3054	62.901
2025	11	19	1	22	15	24.48	94.7	7.2994	59.6672
2025	11	19	1	32	15	25.39	94.7	7.2994	61.868
2025	11	19	1	42	15	24.25	93.8	7.2994	59.1781
2025	11	19	1	52	15	25.22	95.7	7.2994	61.379
2025	11	19	2	2	15	25.69	94.9	7.2994	62.6017
2025	11	19	2	12	15	25.61	95.4	7.2933	62.3027
2025	11	19	2	22	15	25.15	93.6	7.2933	61.3254
2025	11	19	2	32	15	23.46	94.2	7.2933	57.1719
2025	11	19	2	42	15	24.38	94.7	7.2933	59.3708
2025	11	19	2	52	15	24.08	94.5	7.2933	58.6378
2025	11	19	3	2	15	23.87	94.3	7.2933	58.1492
2025	11	19	3	12	15	23.87	94.3	7.2933	58.1492
2025	11	19	3	22	15	24.65	93.7	7.2933	60.1038
2025	11	19	3	32	15	24.82	92.1	7.2933	60.5924
2025	11	19	3	42	15	25.68	94.5	7.2933	62.547
2025	11	19	3	52	15	24.37	94.5	7.2933	59.3708
2025	11	19	4	2	15	24.74	93.2	7.2933	60.3481
2025	11	19	4	12	15	25.19	94.8	7.2933	61.3254
2025	11	19	4	22	15	24.17	94.3	7.2933	58.8821
2025	11	19	4	32	15	25.16	93.9	7.2872	61.2718
2025	11	19	4	42	15	25.94	93.3	7.2872	63.2247
2025	11	19	4	52	15	25.98	94.4	7.2872	63.2247
2025	11	19	5	2	15	24.41	91.9	7.2872	59.563
2025	11	19	5	12	15	24.29	95	7.2872	59.0748
2025	11	19	5	22	15	24.38	94.7	7.2872	59.3189
2025	11	19	5	32	15	25.23	93	7.2811	61.4621
2025	11	19	5	42	15	25.21	95.2	7.2811	61.2182
2025	11	19	5	52	15	24.06	94.1	7.2811	58.5353
2025	11	19	6	2	15	24.37	94.5	7.2811	59.267
2025	11	19	6	12	15	25.05	93.7	7.2811	60.9743
2025	11	19	6	22	15	24.05	93.8	7.2811	58.5353
2025	11	19	6	32	15	24.5	90	7.2811	59.7548
2025	11	19	6	42	15	24.93	93	7.275	60.6773
2025	11	19	6	52	15	25.29	94.8	7.275	61.4083
2025	11	19	7	2	15	25.68	94.5	7.275	62.383
2025	11	19	7	12	15	24.53	92.8	7.275	59.7025
2025	11	19	7	22	15	25.55	93.6	7.275	62.1394
2025	11	19	7	32	15	24.55	93.7	7.275	59.7025
2025	11	19	7	42	15	25.65	93.6	7.275	62.383
2025	11	19	7	52	15	25.21	95.2	7.275	61.1646

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	19	8	2	15	24.43	92.8	7.275	59.4588
2025	11	19	8	12	15	25.43	92.9	7.275	61.8957
2025	11	19	8	22	15	25.49	94.7	7.275	61.8957
2025	11	19	8	32	15	25.02	92.5	7.275	60.9209
2025	11	19	8	42	15	25.06	93.9	7.275	60.9209
2025	11	19	8	52	15	25.29	94.8	7.2689	61.3545
2025	11	19	9	2	15	25.64	93.1	7.2689	62.3284
2025	11	19	9	12	15	25.02	92.5	7.2628	60.8141
2025	11	19	9	22	15	24.47	94.2	7.2628	59.3546
2025	11	19	9	32	15	25.52	92.5	7.2628	62.0304
2025	11	19	9	42	15	25.65	93.6	7.2628	62.2737
2025	11	19	9	52	15	25.65	93.6	7.2567	62.219
2025	11	19	10	2	15	24.98	94.6	7.2567	60.5177
2025	11	19	10	12	15	24.95	93.7	7.2567	60.5176
2025	11	19	10	22	15	26.03	92.6	7.2506	63.1356
2025	11	19	10	32	15	24.67	94.2	7.2506	59.736
2025	11	19	10	42	15	25.8	95.1	7.2506	62.4071
2025	11	19	10	52	15	25.11	91.8	7.2506	60.9501
2025	11	19	11	2	15	25.8	95.1	7.2445	62.3522
2025	11	19	11	12	15	24.87	94.4	7.2445	60.1687
2025	11	19	11	22	15	24.73	92.8	7.2445	59.926
2025	11	19	11	32	15	25.26	93.9	7.2445	61.1391
2025	11	19	11	42	15	25.95	93.5	7.2445	62.8374
2025	11	19	11	52	15	25.05	93.7	7.2445	60.6538
2025	11	19	12	2	15	24.83	92.8	7.2445	60.1686
2025	11	19	12	12	15	25.27	94.3	7.2445	61.139
2025	11	19	12	22	15	24.51	91.4	7.2445	59.4407
2025	11	19	12	32	15	25.65	93.6	7.2445	62.1094
2025	11	19	12	42	15	25.35	93.6	7.2445	61.3816
2025	11	19	12	52	15	25.14	93.4	7.2445	60.8964
2025	11	19	13	2	15	24.75	93.7	7.2384	59.8732
2025	11	19	13	12	15	24.77	94.4	7.2384	59.8731
2025	11	19	13	22	15	25.14	93.4	7.2445	60.8963
2025	11	19	13	32	15	25.05	93.7	7.2445	60.6536
2025	11	19	13	42	15	24.55	93.7	7.2384	59.3883
2025	11	19	13	52	15	23.16	94	7.2384	55.9947
2025	11	19	14	2	15	24	91	7.2384	58.1763
2025	11	19	14	12	15	24	91	7.2384	58.1763
2025	11	19	14	22	15	24.63	95.8	7.2384	59.3883
2025	11	19	14	32	15	25.49	94.7	7.2384	61.5699
2025	11	19	14	42	15	24.72	92.5	7.2384	59.8731
2025	11	19	14	52	15	25.11	91.6	7.2384	60.8426
2025	11	19	15	2	15	24.85	93.7	7.2323	60.0625
2025	11	19	15	12	15	24.32	92.4	7.2323	58.8516
2025	11	19	15	22	15	24.87	94.2	7.2323	60.0625
2025	11	19	15	32	15	23.62	92.4	7.2323	57.1563
2025	11	19	15	42	15	24.25	93.8	7.2323	58.6094
2025	11	19	15	52	15	24.95	93.7	7.2323	60.3047

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	19	16	2	15	24.63	93	7.2262	59.5257
2025	11	19	16	12	15	24.68	94.6	7.2262	59.5257
2025	11	19	16	22	15	24.09	95	7.2262	58.0738
2025	11	19	16	32	15	24.52	95.6	7.2262	59.0417
2025	11	19	16	42	15	25.32	92	7.2262	61.2195
2025	11	19	16	52	15	24.07	94.3	7.2201	58.0226
2025	11	19	17	2	15	23.41	95.6	7.2201	56.3303
2025	11	19	17	12	15	23.65	93.6	7.2201	57.0556
2025	11	19	17	22	15	25.38	94.5	7.2201	61.1655
2025	11	19	17	32	15	24.26	94	7.2201	58.5061
2025	11	19	17	42	15	25.19	94.8	7.2201	60.682
2025	11	19	17	52	15	24.49	94.9	7.214	58.9376
2025	11	19	18	2	15	25.92	95.5	7.214	62.3192
2025	11	19	18	12	15	24.88	94.6	7.214	59.9038
2025	11	19	18	22	15	24.59	94.9	7.214	59.1791
2025	11	19	18	32	15	25.59	94.7	7.214	61.5946
2025	11	19	18	42	15	25.43	92.9	7.214	61.3531
2025	11	19	18	52	15	24.69	94.9	7.214	59.4207
2025	11	19	19	2	15	23.87	94.3	7.2079	57.4375
2025	11	19	19	12	15	24.35	93.8	7.2079	58.6442
2025	11	19	19	22	15	24.54	96.1	7.2018	58.8335
2025	11	19	19	32	15	23.14	93.2	7.1957	55.6496
2025	11	19	19	42	15	24	95.3	7.1957	57.5769
2025	11	19	19	52	15	24.83	93	7.2018	59.798
2025	11	19	20	2	15	25.77	94.2	7.1957	61.9132
2025	11	19	20	12	15	24.39	94.9	7.1896	58.4887
2025	11	19	20	22	15	24.65	93.7	7.1896	59.2107
2025	11	19	20	32	15	24.85	93.7	7.1896	59.6921
2025	11	19	20	42	15	25.33	92.7	7.1835	60.8416
2025	11	19	20	52	15	24.05	93.8	7.1774	57.6642
2025	11	19	21	2	15	24.1	95.2	7.1774	57.6642
2025	11	19	21	12	15	24.41	95.4	7.1774	58.385
2025	11	19	21	22	15	24.74	96	7.1774	59.1058
2025	11	19	21	32	15	25.12	95.7	7.1774	60.0669
2025	11	19	21	42	15	23.94	93.1	7.1774	57.4239
2025	11	19	21	52	15	24.46	94	7.1713	58.5732
2025	11	19	22	2	15	24.42	92.6	7.1713	58.5732
2025	11	19	22	12	15	25.76	94	7.1713	61.6939
2025	11	19	22	22	15	24.6	95.1	7.1713	58.8133
2025	11	19	22	32	15	24.05	93.8	7.1713	57.613
2025	11	19	22	42	15	24.43	93	7.1713	58.5732
2025	11	19	22	52	15	24.3	95.2	7.1713	58.0931
2025	11	19	23	2	15	23.95	93.8	7.1713	57.373
2025	11	19	23	12	15	24.73	92.8	7.1652	59.2407
2025	11	19	23	22	15	24.08	94.5	7.1652	57.5618
2025	11	19	23	32	15	24.12	92.4	7.1652	57.8017
2025	11	19	23	42	15	25.14	93.4	7.1652	60.2001
2025	11	19	23	52	15	23.96	94.1	7.1652	57.322

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	20	0	2	15	23.51	91.2	7.1652	56.3626
2025	11	20	0	12	15	24.05	93.8	7.1652	57.5619
2025	11	20	0	22	15	24.63	92.8	7.1591	58.9484
2025	11	20	0	32	15	24.17	94.3	7.1591	57.7503
2025	11	20	0	42	15	23.56	94.1	7.1591	56.3125
2025	11	20	0	52	15	23.5	91	7.1591	56.3125
2025	11	20	1	2	15	24.47	94.2	7.1591	58.4692
2025	11	20	1	12	15	24.14	93.1	7.1591	57.7503
2025	11	20	1	22	15	24.54	93.3	7.153	58.6565
2025	11	20	1	32	15	23.81	91.9	7.1591	57.0314
2025	11	20	1	42	15	23.54	93.2	7.1591	56.3126
2025	11	20	1	52	15	24.48	94.7	7.1591	58.4692
2025	11	20	2	2	15	24.72	92.5	7.153	59.1354
2025	11	20	2	12	15	24.21	91.4	7.153	57.9383
2025	11	20	2	22	15	24.04	93.3	7.153	57.4595
2025	11	20	2	32	15	24.06	94.1	7.153	57.4595
2025	11	20	2	42	15	23.98	94.8	7.153	57.2201
2025	11	20	2	52	15	23.97	94.3	7.153	57.2201
2025	11	20	3	2	15	23.52	92.2	7.153	56.2624
2025	11	20	3	12	15	23.91	95.5	7.153	56.9807
2025	11	20	3	22	15	24.11	91.7	7.153	57.6989
2025	11	20	3	32	15	24.43	92.8	7.153	58.4171
2025	11	20	3	42	15	24.31	91.7	7.153	58.1777
2025	11	20	3	52	15	23.06	94.2	7.153	55.0653
2025	11	20	4	2	15	24.19	95	7.153	57.6989
2025	11	20	4	12	15	24.43	95.9	7.153	58.1777
2025	11	20	4	22	15	23.89	95	7.153	56.9807
2025	11	20	4	32	15	24.4	95.2	7.153	58.1777
2025	11	20	4	42	15	23.58	94.6	7.153	56.2624
2025	11	20	4	52	15	24.09	95	7.147	57.4083
2025	11	20	5	2	15	23.44	96.4	7.147	55.7339
2025	11	20	5	12	15	24.77	94.4	7.147	59.0827
2025	11	20	5	22	15	24.37	94.2	7.147	58.1259
2025	11	20	5	32	15	24.43	95.9	7.147	58.1259
2025	11	20	5	42	15	23.76	94.1	7.147	56.6907
2025	11	20	5	52	15	23.32	95.9	7.147	55.4947
2025	11	20	6	2	15	24.05	93.8	7.147	57.4083
2025	11	20	6	12	15	24.86	93.9	7.147	59.3219
2025	11	20	6	22	15	23.87	94.3	7.147	56.9299
2025	11	20	6	32	15	24.47	94.2	7.147	58.3651
2025	11	20	6	42	15	24.35	93.5	7.147	58.1259
2025	11	20	6	52	15	24.32	97.8	7.147	57.6475
2025	11	20	7	2	15	23.95	93.6	7.147	57.1691
2025	11	20	7	12	15	24.39	94.9	7.147	58.1259
2025	11	20	7	22	15	24.1	97.4	7.147	57.1691
2025	11	20	7	32	15	24.03	96	7.147	57.1691
2025	11	20	7	42	15	24.01	95.5	7.147	57.1691
2025	11	20	7	52	15	24.49	94.9	7.147	58.3651

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	20	8	2	15	25.71	97.4	7.147	60.9963
2025	11	20	8	12	15	24.12	95.7	7.1409	57.3571
2025	11	20	8	22	15	24.15	93.8	7.147	57.6475
2025	11	20	8	32	15	25.01	95.3	7.147	59.5611
2025	11	20	8	42	15	24.79	97.2	7.147	58.8435
2025	11	20	8	52	15	24.82	95.5	7.147	59.0827
2025	11	20	9	2	15	23.32	95.9	7.147	55.4947
2025	11	20	9	12	15	23.67	94.4	7.147	56.4515
2025	11	20	9	22	15	25.37	98.4	7.147	60.0395
2025	11	20	9	32	15	23.93	92.9	7.147	57.169
2025	11	20	9	42	15	24.98	96.9	7.147	59.3218
2025	11	20	9	52	15	23.14	96.2	7.147	55.0162
2025	11	20	10	2	15	25.05	93.7	7.147	59.8002
2025	11	20	10	12	15	24.92	97.6	7.147	59.0826
2025	11	20	10	22	15	23.98	94.8	7.147	57.169
2025	11	20	10	32	15	25.37	96.6	7.147	60.2786
2025	11	20	10	42	15	22.79	95	7.147	54.2985
2025	11	20	10	52	15	23.19	97.4	7.147	55.0161
2025	11	20	11	2	15	25.29	94.8	7.153	60.3323
2025	11	20	11	12	15	24.83	95.8	7.153	59.1352
2025	11	20	11	22	15	23.31	97.6	7.153	55.3046
2025	11	20	11	32	15	24.52	95.6	7.153	58.417
2025	11	20	11	42	15	24.68	97	7.153	58.6564
2025	11	20	11	52	15	24.04	98.1	7.153	56.9805
2025	11	20	12	2	15	23.46	94.2	7.153	56.0228
2025	11	20	12	12	15	23.8	95.3	7.153	56.7411
2025	11	20	12	22	15	23.98	94.8	7.153	57.2199
2025	11	20	12	32	15	24.39	94.9	7.153	58.1775
2025	11	20	12	42	15	24.59	94.9	7.153	58.6564
2025	11	20	12	52	15	25.75	96.2	7.153	61.2899
2025	11	20	13	2	15	24.24	96.2	7.153	57.6987
2025	11	20	13	12	15	24.41	91.4	7.153	58.417
2025	11	20	13	22	15	25.23	95.9	7.153	60.0929
2025	11	20	13	32	15	24.68	97	7.153	58.6564
2025	11	20	13	42	15	23.94	93.1	7.1591	57.2709
2025	11	20	13	52	15	24.25	93.8	7.1591	57.9898
2025	11	20	14	2	15	24.21	91.4	7.1591	57.9898
2025	11	20	14	12	15	24.76	93.9	7.1591	59.1879
2025	11	20	14	22	15	25.3	95	7.1591	60.3861
2025	11	20	14	32	15	24.97	96.7	7.1591	59.4276
2025	11	20	14	42	15	23.35	93.7	7.1591	55.8332
2025	11	20	14	52	15	24.26	94	7.1591	57.9898
2025	11	20	15	2	15	23.05	93.7	7.1591	55.1143
2025	11	20	15	12	15	24.05	93.8	7.1591	57.5106
2025	11	20	15	22	15	24.85	93.7	7.1652	59.4805
2025	11	20	15	32	15	24.13	92.9	7.1591	57.7502
2025	11	20	15	42	15	25.49	94.7	7.1591	60.8654
2025	11	20	15	52	15	24.33	93.1	7.1652	58.2813

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	20	16	2	15	24.41	95.4	7.1652	58.2814
2025	11	20	16	12	15	26.02	92.4	7.1652	62.3587
2025	11	20	16	22	15	24.85	93.7	7.1652	59.4806
2025	11	20	16	32	15	25.62	95.6	7.1652	61.1595
2025	11	20	16	42	15	24.96	94.1	7.1652	59.7204
2025	11	20	16	52	15	26.45	93.7	7.1713	63.3744
2025	11	20	17	2	15	25.22	95.7	7.1713	60.2537
2025	11	20	17	12	15	25.85	93.5	7.1774	61.9892
2025	11	20	17	22	15	26.58	94.5	7.1774	63.6711
2025	11	20	17	32	15	26.28	94.6	7.1835	63.0062
2025	11	20	17	42	15	27.22	95.3	7.1957	65.2862
2025	11	20	17	52	15	25.18	96.8	7.1957	60.2272
2025	11	20	18	2	15	25.42	95.6	7.2018	61.0039
2025	11	20	18	12	15	25.53	92.7	7.2018	61.4862
2025	11	20	18	22	15	25.98	94.6	7.2079	62.506
2025	11	20	18	32	15	25.22	95.7	7.2079	60.5753
2025	11	20	18	42	15	25.63	92.7	7.214	61.8366
2025	11	20	18	52	15	24.52	92.6	7.214	59.1796
2025	11	20	19	2	15	25.67	94.2	7.2201	61.8913
2025	11	20	19	12	15	26.43	92.6	7.2201	63.8254
2025	11	20	19	22	15	25.28	94.5	7.2201	60.9243
2025	11	20	19	32	15	25.19	94.8	7.2201	60.6825
2025	11	20	19	42	15	26.79	96.9	7.2262	64.3658
2025	11	20	19	52	15	25.81	95.3	7.2262	62.188
2025	11	20	20	2	15	25.59	94.7	7.2262	61.7041
2025	11	20	20	12	15	25.49	94.7	7.2262	61.4621
2025	11	20	20	22	15	25.8	95.1	7.2323	62.2429
2025	11	20	20	32	15	26.74	95.8	7.2323	64.4226
2025	11	20	20	42	15	25.76	96.5	7.2323	62.0008
2025	11	20	20	52	15	25.8	95.1	7.2323	62.243
2025	11	20	21	2	15	25.53	95.8	7.2384	61.5706
2025	11	20	21	12	15	25.16	96.4	7.2384	60.601
2025	11	20	21	22	15	26.52	95.4	7.2384	63.9947
2025	11	20	21	32	15	25.92	97.5	7.2445	62.3527
2025	11	20	21	42	15	24.98	94.6	7.2506	60.465
2025	11	20	21	52	15	25.99	96.9	7.2567	62.7055
2025	11	20	22	2	15	25.46	93.8	7.2567	61.7334
2025	11	20	22	12	15	26.36	96.3	7.2689	63.7896
2025	11	20	22	22	15	25.67	98.3	7.2689	61.8419
2025	11	20	22	32	15	26.36	96.3	7.2689	63.7896
2025	11	20	22	42	15	25.31	95.4	7.2689	61.3549
2025	11	20	22	52	15	25.23	97.7	7.2689	60.868
2025	11	20	23	2	15	26.31	95.2	7.275	63.8456
2025	11	20	23	12	15	26.72	95.4	7.275	64.8204
2025	11	20	23	22	15	24.66	98.4	7.275	59.4593
2025	11	20	23	32	15	25.34	97.9	7.275	61.1651
2025	11	20	23	42	15	26.21	95.3	7.275	63.602
2025	11	20	23	52	15	26.36	98.1	7.275	63.602

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	21	0	2	15	24.73	93	7.275	60.1904
2025	11	21	0	12	15	25.48	96.8	7.275	61.6525
2025	11	21	0	22	15	23.8	97.5	7.2811	57.5602
2025	11	21	0	32	15	25.07	96.6	7.275	60.6778
2025	11	21	0	42	15	24.66	96.5	7.275	59.703
2025	11	21	0	52	15	26.22	95.5	7.275	63.602
2025	11	21	1	2	15	25.71	97.4	7.275	62.1399
2025	11	21	1	12	15	25.78	94.4	7.275	62.6273
2025	11	21	1	22	15	24.57	94.4	7.275	59.7031
2025	11	21	1	32	15	24.9	95.1	7.275	60.4341
2025	11	21	1	42	15	24.15	96.4	7.275	58.4846
2025	11	21	1	52	15	25.66	96.5	7.275	62.14
2025	11	21	2	2	15	25	95	7.275	60.6778
2025	11	21	2	12	15	23.97	94.3	7.275	58.241
2025	11	21	2	22	15	25.21	95.5	7.275	61.1652
2025	11	21	2	32	15	25.31	95.4	7.275	61.4089
2025	11	21	2	42	15	24.58	94.7	7.275	59.7031
2025	11	21	2	52	15	24.89	97.2	7.275	60.1905
2025	11	21	3	2	15	25.96	96.4	7.275	62.871
2025	11	21	3	12	15	24.55	93.5	7.275	59.7031
2025	11	21	3	22	15	25.11	95.3	7.275	60.9215
2025	11	21	3	32	15	26.06	94	7.275	63.3584
2025	11	21	3	42	15	26.04	96	7.2689	63.0594
2025	11	21	3	52	15	25.44	96.1	7.2689	61.5986
2025	11	21	4	2	15	25.22	95.7	7.2689	61.1116
2025	11	21	4	12	15	26.35	93.5	7.2689	64.0333
2025	11	21	4	22	15	25.39	94.7	7.2689	61.5986
2025	11	21	4	32	15	25.02	95.5	7.2689	60.6247
2025	11	21	4	42	15	25.11	95.3	7.2689	60.8682
2025	11	21	4	52	15	25.04	96	7.2689	60.6247
2025	11	21	5	2	15	24.64	93.3	7.2689	59.8943
2025	11	21	5	12	15	25.12	95.7	7.2689	60.8682
2025	11	21	5	22	15	24.77	94.2	7.2689	60.1377
2025	11	21	5	32	15	24.78	94.6	7.2689	60.1377
2025	11	21	5	42	15	25.4	95	7.2628	61.5446
2025	11	21	5	52	15	25.89	94.7	7.2628	62.7609
2025	11	21	6	2	15	26.87	96.4	7.2628	64.9502
2025	11	21	6	12	15	26.08	94.6	7.2567	63.1919
2025	11	21	6	22	15	25.63	95.8	7.2628	62.0311
2025	11	21	6	32	15	25.5	97.2	7.2628	61.5446
2025	11	21	6	42	15	25.24	96.1	7.2628	61.058
2025	11	21	6	52	15	26.13	95.7	7.2567	63.1919
2025	11	21	7	2	15	26.87	96.4	7.2506	64.8362
2025	11	21	7	12	15	25.43	92.9	7.2445	61.6251
2025	11	21	7	22	15	25.81	95.3	7.2384	62.2981
2025	11	21	7	32	15	25.24	96.1	7.2384	60.8437
2025	11	21	7	42	15	27.12	95.3	7.2384	65.4494
2025	11	21	7	52	15	26.58	94.5	7.2384	64.2374

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	21	8	2	15	26.35	97.9	7.2323	63.212
2025	11	21	8	12	15	24.99	94.8	7.2323	60.3057
2025	11	21	8	22	15	26.19	94.8	7.2323	63.212
2025	11	21	8	32	15	25.17	96.6	7.2323	60.5479
2025	11	21	8	42	15	25.76	96.5	7.2323	62.001
2025	11	21	8	52	15	25.33	95.9	7.2323	61.0323
2025	11	21	9	2	15	25.04	96	7.2323	60.3057
2025	11	21	9	12	15	24.83	95.8	7.2323	59.8213
2025	11	21	9	22	15	25.26	94.1	7.2323	61.0323
2025	11	21	9	32	15	25.06	94.1	7.2323	60.5479
2025	11	21	9	42	15	26.19	94.8	7.2262	63.1563
2025	11	21	9	52	15	25.03	95.7	7.2262	60.2525
2025	11	21	10	2	15	25.07	96.6	7.2262	60.2525
2025	11	21	10	12	15	24.59	94.9	7.2262	59.2846
2025	11	21	10	22	15	25.33	92.7	7.2262	61.2204
2025	11	21	10	32	15	25.42	92.3	7.2262	61.4624
2025	11	21	10	42	15	24.59	94.9	7.2262	59.2846
2025	11	21	10	52	15	24.97	94.4	7.2262	60.2525
2025	11	21	11	2	15	25.17	94.3	7.2262	60.7364
2025	11	21	11	12	15	24.69	94.9	7.2262	59.5265
2025	11	21	11	22	15	23.45	93.9	7.2201	56.5728
2025	11	21	11	32	15	24.08	94.5	7.2201	58.0234
2025	11	21	11	42	15	24.23	95.9	7.2201	58.2652
2025	11	21	11	52	15	25.89	96.9	7.2201	62.1334
2025	11	21	12	2	15	24.36	94	7.2201	58.7487
2025	11	21	12	12	15	25.06	93.9	7.2201	60.4411
2025	11	21	12	22	15	25.83	95.8	7.2201	62.1334
2025	11	21	12	32	15	25.28	96.8	7.2201	60.6828
2025	11	21	12	42	15	25.96	93.8	7.2201	62.6169
2025	11	21	12	52	15	26.65	93.4	7.2201	64.3093
2025	11	21	13	2	15	25.8	95.1	7.214	62.0785
2025	11	21	13	12	15	24.71	95.3	7.2201	59.474
2025	11	21	13	22	15	25.34	93.2	7.214	61.1123
2025	11	21	13	32	15	24.68	94.6	7.214	59.4214
2025	11	21	13	42	15	23.88	94.6	7.214	57.489
2025	11	21	13	52	15	25.2	95	7.214	60.6292
2025	11	21	14	2	15	24.75	93.7	7.214	59.663
2025	11	21	14	12	15	24.25	93.5	7.214	58.4552
2025	11	21	14	22	15	25.06	93.9	7.214	60.3876
2025	11	21	14	32	15	25.4	95	7.214	61.1123
2025	11	21	14	42	15	25.65	93.6	7.214	61.8369
2025	11	21	14	52	15	25.17	96.6	7.214	60.3876
2025	11	21	15	2	15	24.75	93.7	7.214	59.663
2025	11	21	15	12	15	23.04	93.2	7.214	55.5566
2025	11	21	15	22	15	24.64	93.3	7.214	59.4214
2025	11	21	15	32	15	24.42	95.6	7.2079	58.6449
2025	11	21	15	42	15	23.75	93.9	7.2079	57.1969
2025	11	21	15	52	15	23.49	95.1	7.2079	56.4729

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	21	16	2	15	23.48	97.1	7.2079	56.2316
2025	11	21	16	12	15	23.63	96.1	7.2079	56.7142
2025	11	21	16	22	15	23.77	94.3	7.2079	57.1969
2025	11	21	16	32	15	23.95	93.6	7.2079	57.6796
2025	11	21	16	42	15	22.81	91.8	7.2018	54.9762
2025	11	21	16	52	15	25.83	95.8	7.2079	62.0237
2025	11	21	17	2	15	23.75	93.9	7.2018	57.1463
2025	11	21	17	12	15	23.15	93.7	7.2018	55.6996
2025	11	21	17	22	15	25.08	94.6	7.2018	60.281
2025	11	21	17	32	15	24.67	94.4	7.2018	59.3165
2025	11	21	17	42	15	24.55	93.7	7.2018	59.0753
2025	11	21	17	52	15	23.54	93.2	7.2018	56.6641
2025	11	21	18	2	15	23.02	95.7	7.1957	55.1685
2025	11	21	18	12	15	23.94	93.1	7.1957	57.5776
2025	11	21	18	22	15	24.65	93.7	7.1957	59.264
2025	11	21	18	32	15	23.37	94.4	7.1957	56.1322
2025	11	21	18	42	15	24.53	93	7.1957	59.0231
2025	11	21	18	52	15	25.03	95.7	7.1896	59.9336
2025	11	21	19	2	15	24.31	95.4	7.1896	58.2487
2025	11	21	19	12	15	26.08	94.6	7.1896	62.5813
2025	11	21	19	22	15	23.64	93.2	7.1896	56.8045
2025	11	21	19	32	15	23.83	96	7.1835	56.9947
2025	11	21	19	42	15	23.41	95.6	7.1774	55.983
2025	11	21	19	52	15	26.04	96	7.1774	62.23
2025	11	21	20	2	15	24.7	95.1	7.1713	59.054
2025	11	21	20	12	15	23.98	96.9	7.1652	57.0828
2025	11	21	20	22	15	24.65	96.3	7.1652	58.7617
2025	11	21	20	32	15	25.03	95.7	7.1652	59.7211
2025	11	21	20	42	15	25.66	99.6	7.1652	60.6804
2025	11	21	20	52	15	24.64	96.1	7.1652	58.7617
2025	11	21	21	2	15	24.78	97	7.1591	58.949
2025	11	21	21	12	15	23.92	92.4	7.1591	57.2716
2025	11	21	21	22	15	23.89	97.2	7.1591	56.7924
2025	11	21	21	32	15	23.78	97	7.1591	56.5528
2025	11	21	21	42	15	24.47	94.2	7.1591	58.4698
2025	11	21	21	52	15	23.36	94.2	7.1591	55.8339
2025	11	21	22	2	15	24.05	93.8	7.153	57.4601
2025	11	21	22	12	15	24.55	93.7	7.153	58.6572
2025	11	21	22	22	15	24.03	92.9	7.153	57.4601
2025	11	21	22	32	15	24.75	93.7	7.153	59.136
2025	11	21	22	42	15	26.34	93.3	7.153	62.9667
2025	11	21	22	52	15	24.58	94.7	7.153	58.6572
2025	11	21	23	2	15	24.95	96.2	7.153	59.3754
2025	11	21	23	12	15	24.56	96.5	7.153	58.4178
2025	11	21	23	22	15	23.66	94.1	7.153	56.5024
2025	11	21	23	32	15	23.73	98	7.153	56.263
2025	11	21	23	42	15	24.45	93.5	7.153	58.4178
2025	11	21	23	52	15	24.37	94.5	7.147	58.1265

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	22	0	2	15	24.43	93	7.147	58.3657
2025	11	22	0	12	15	25.46	94.1	7.147	60.7577
2025	11	22	0	22	15	24.31	95.4	7.147	57.8873
2025	11	22	0	32	15	24.16	94	7.147	57.6481
2025	11	22	0	42	15	24.42	92.3	7.147	58.3657
2025	11	22	0	52	15	25.82	95.6	7.147	61.4754
2025	11	22	1	2	15	24.53	92.8	7.147	58.6049
2025	11	22	1	12	15	23.75	93.6	7.147	56.6913
2025	11	22	1	22	15	25.23	93	7.1409	60.2256
2025	11	22	1	32	15	25.41	95.4	7.1409	60.4645
2025	11	22	1	42	15	24.23	95.9	7.1409	57.5967
2025	11	22	1	52	15	23.45	93.9	7.1409	55.9237
2025	11	22	2	2	15	24.48	94.7	7.1409	58.3136
2025	11	22	2	12	15	24.66	94	7.1409	58.7916
2025	11	22	2	22	15	24.15	93.6	7.1409	57.5967
2025	11	22	2	32	15	24.48	94.7	7.1409	58.3136
2025	11	22	2	42	15	25.47	96.5	7.1409	60.4645
2025	11	22	2	52	15	23.92	95.8	7.1409	56.8797
2025	11	22	3	2	15	25.13	95.9	7.1409	59.7476
2025	11	22	3	12	15	22.86	94.3	7.1348	54.4411
2025	11	22	3	22	15	25.61	95.4	7.1348	60.8881
2025	11	22	3	32	15	25.07	96.6	7.1348	59.4554
2025	11	22	3	42	15	25.47	96.5	7.1409	60.4645
2025	11	22	3	52	15	24.62	95.6	7.1348	58.5003
2025	11	22	4	2	15	24.58	94.7	7.1348	58.5003
2025	11	22	4	12	15	26.1	95.1	7.1348	62.082
2025	11	22	4	22	15	26.06	94	7.1348	62.082
2025	11	22	4	32	15	24.9	95.1	7.1287	59.1637
2025	11	22	4	42	15	24.45	93.5	7.1287	58.2095
2025	11	22	4	52	15	25.9	95.1	7.1287	61.5494
2025	11	22	5	2	15	25.61	95.4	7.1287	60.8337
2025	11	22	5	12	15	25.36	93.8	7.1287	60.3565
2025	11	22	5	22	15	25.81	95.3	7.1287	61.3108
2025	11	22	5	32	15	24.64	96.1	7.1287	58.448
2025	11	22	5	42	15	26.85	96	7.1287	63.6964
2025	11	22	5	52	15	24.36	94	7.1287	57.9709
2025	11	22	6	2	15	24.51	95.4	7.1287	58.2095
2025	11	22	6	12	15	25.11	95.3	7.1287	59.6409
2025	11	22	6	22	15	25.58	96.7	7.1287	60.5951
2025	11	22	6	32	15	25.79	94.7	7.1287	61.3108
2025	11	22	6	42	15	24.89	94.8	7.1226	59.1108
2025	11	22	6	52	15	24.85	93.7	7.1226	59.1108
2025	11	22	7	2	15	25.58	94.5	7.1287	60.8337
2025	11	22	7	12	15	26.15	96.1	7.1287	62.0265
2025	11	22	7	22	15	25.28	96.8	7.1287	59.8794
2025	11	22	7	32	15	26.05	97.9	7.1287	61.5494
2025	11	22	7	42	15	25.58	96.7	7.1287	60.5951
2025	11	22	7	52	15	25.53	97.7	7.1226	60.3025

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	22	8	2	15	25	95	7.1165	59.296
2025	11	22	8	12	15	24.22	95.7	7.1226	57.4423
2025	11	22	8	22	15	24.35	99.7	7.1226	57.204
2025	11	22	8	32	15	24.55	98.2	7.1226	57.919
2025	11	22	8	42	15	24.97	96.7	7.1226	59.1108
2025	11	22	8	52	15	24.97	94.4	7.1226	59.3491
2025	11	22	9	2	15	25.87	96.7	7.1226	61.2559
2025	11	22	9	12	15	26.07	96.6	7.1165	61.6774
2025	11	22	9	22	15	24.17	94.5	7.1104	57.3395
2025	11	22	9	32	15	23.99	97.2	7.1043	56.5749
2025	11	22	9	42	15	23.83	96	7.1104	56.3878
2025	11	22	9	52	15	25.36	96.3	7.1104	59.9566
2025	11	22	10	2	15	25.3	97.3	7.1043	59.6651
2025	11	22	10	12	15	25.2	95	7.0982	59.6116
2025	11	22	10	22	15	25.21	95.5	7.0982	59.6115
2025	11	22	10	32	15	25.37	94.3	7.0982	60.0865
2025	11	22	10	42	15	23.99	97.2	7.0982	56.5241
2025	11	22	10	52	15	25.24	96.1	7.0921	59.558
2025	11	22	11	2	15	25.49	94.7	7.0982	60.324
2025	11	22	11	12	15	25.29	94.8	7.0921	59.7953
2025	11	22	11	22	15	24.92	95.5	7.0921	58.8461
2025	11	22	11	32	15	26.01	95.3	7.0921	61.4562
2025	11	22	11	42	15	26.47	94.1	7.0921	62.6426
2025	11	22	11	52	15	25.16	93.9	7.0921	59.5579
2025	11	22	12	2	15	25.04	96	7.0921	59.0834
2025	11	22	12	12	15	25.24	96.1	7.0921	59.5579
2025	11	22	12	22	15	24.06	94.1	7.0921	56.9478
2025	11	22	12	32	15	25.98	94.4	7.0921	61.4562
2025	11	22	12	42	15	26.46	96.3	7.086	62.3492
2025	11	22	12	52	15	25.86	93.8	7.086	61.1638
2025	11	22	13	2	15	25.88	94.4	7.086	61.1638
2025	11	22	13	12	15	25.01	95.3	7.086	59.0302
2025	11	22	13	22	15	25.22	95.7	7.086	59.5043
2025	11	22	13	32	15	25.11	95.5	7.086	59.2672
2025	11	22	13	42	15	25.76	94	7.086	60.9267
2025	11	22	13	52	15	25.97	94.2	7.086	61.4008
2025	11	22	14	2	15	25.39	94.7	7.086	59.9784
2025	11	22	14	12	15	24.72	97.7	7.086	58.0818
2025	11	22	14	22	15	26.22	95.5	7.086	61.8749
2025	11	22	14	32	15	24.71	97.4	7.086	58.0818
2025	11	22	14	42	15	24.77	94.2	7.086	58.556
2025	11	22	14	52	15	25.18	96.8	7.086	59.2671
2025	11	22	15	2	15	24.73	95.8	7.086	58.3189
2025	11	22	15	12	15	25.61	97.4	7.086	60.2154
2025	11	22	15	22	15	25.58	94.5	7.086	60.4525
2025	11	22	15	32	15	24.72	95.6	7.086	58.3189
2025	11	22	15	42	15	24.87	96.7	7.0799	58.5033
2025	11	22	15	52	15	26.15	96.1	7.086	61.6379

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	22	16	2	15	24.86	93.9	7.0799	58.7401
2025	11	22	16	12	15	24.34	96.1	7.0799	57.319
2025	11	22	16	22	15	24.31	95.4	7.0799	57.319
2025	11	22	16	32	15	25.12	95.7	7.086	59.2672
2025	11	22	16	42	15	25.2	97.3	7.0799	59.2138
2025	11	22	16	52	15	24.71	97.4	7.0799	58.0295
2025	11	22	17	2	15	26.15	96.1	7.0799	61.5824
2025	11	22	17	12	15	26.67	98.2	7.0799	62.5298
2025	11	22	17	22	15	25.17	96.6	7.0799	59.2138
2025	11	22	17	32	15	25.41	95.4	7.0799	59.9244
2025	11	22	17	42	15	25.74	96	7.0799	60.635
2025	11	22	17	52	15	24.72	97.7	7.0799	58.0296
2025	11	22	18	2	15	24.9	95.1	7.0799	58.7402
2025	11	22	18	12	15	24.23	95.9	7.0799	57.0822
2025	11	22	18	22	15	24.27	94.5	7.0799	57.319
2025	11	22	18	32	15	24.06	96.7	7.0799	56.6085
2025	11	22	18	42	15	25.42	95.6	7.0799	59.9244
2025	11	22	18	52	15	25.37	96.6	7.0738	59.6338
2025	11	22	19	2	15	25.98	94.4	7.0799	61.3456
2025	11	22	19	12	15	24.83	95.8	7.0799	58.5033
2025	11	22	19	22	15	24.56	96.5	7.0738	57.7407
2025	11	22	19	32	15	24.26	96.6	7.0738	57.0308
2025	11	22	19	42	15	25.28	96.8	7.0738	59.3972
2025	11	22	19	52	15	24.24	96.2	7.0738	57.0308
2025	11	22	20	2	15	24.27	96.9	7.0738	57.0308
2025	11	22	20	12	15	24.67	96.8	7.0738	57.9774
2025	11	22	20	22	15	25.84	97.8	7.0738	60.5805
2025	11	22	20	32	15	25.03	95.7	7.0738	58.924
2025	11	22	20	42	15	25.22	95.7	7.0738	59.3972
2025	11	22	20	52	15	24.71	97.4	7.0738	57.9774
2025	11	22	21	2	15	23.8	95.3	7.0738	56.0843
2025	11	22	21	12	15	24.36	96.6	7.0738	57.2675
2025	11	22	21	22	15	25.63	95.8	7.0738	60.3439
2025	11	22	21	32	15	23.93	96	7.0738	56.3209
2025	11	22	21	42	15	25.06	96.4	7.0738	58.924
2025	11	22	21	52	15	24.54	96.1	7.0738	57.7408
2025	11	22	22	2	15	24.67	94.4	7.0738	58.2141
2025	11	22	22	12	15	23.73	98	7.0738	55.611
2025	11	22	22	22	15	25.21	95.5	7.0738	59.3973
2025	11	22	22	32	15	24.89	97.2	7.0677	58.398
2025	11	22	22	42	15	25.05	98	7.0677	58.6345
2025	11	22	22	52	15	24.69	94.9	7.0677	58.1616
2025	11	22	23	2	15	24.12	95.7	7.0677	56.7431
2025	11	22	23	12	15	24.95	96.2	7.0677	58.6345
2025	11	22	23	22	15	26.36	96.3	7.0677	61.9445
2025	11	22	23	32	15	25.87	96.7	7.0677	60.7624
2025	11	22	23	42	15	25.13	97.8	7.0677	58.871
2025	11	22	23	52	15	25.17	96.6	7.0677	59.1074

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	23	0	2	15	24.84	96	7.0677	58.3981
2025	11	23	0	12	15	24.2	95.2	7.0677	56.9796
2025	11	23	0	22	15	25.5	97.2	7.0677	59.8167
2025	11	23	0	32	15	25.57	96.5	7.0677	60.0532
2025	11	23	0	42	15	24.61	95.4	7.0677	57.9253
2025	11	23	0	52	15	24.97	96.7	7.0616	58.5817
2025	11	23	1	2	15	25.61	97.4	7.0616	59.999
2025	11	23	1	12	15	24.67	96.8	7.0616	57.8731
2025	11	23	1	22	15	24.31	97.6	7.0616	56.9282
2025	11	23	1	32	15	24.17	94.3	7.0616	56.9282
2025	11	23	1	42	15	22.96	96.8	7.0616	53.8574
2025	11	23	1	52	15	25.81	97.3	7.0616	60.4715
2025	11	23	2	2	15	23.73	96	7.0616	55.7472
2025	11	23	2	12	15	24.77	96.7	7.0616	58.1094
2025	11	23	2	22	15	25.12	97.5	7.0616	58.818
2025	11	23	2	32	15	23.75	96.5	7.0616	55.7472
2025	11	23	2	42	15	25.12	97.5	7.0616	58.818
2025	11	23	2	52	15	24.17	96.9	7.0555	56.6409
2025	11	23	3	2	15	24.82	97.6	7.0555	58.0569
2025	11	23	3	12	15	24.29	97.1	7.0555	56.8769
2025	11	23	3	22	15	23.79	97.2	7.0555	55.6969
2025	11	23	3	32	15	24.06	96.7	7.0555	56.4049
2025	11	23	3	42	15	23.68	97	7.0555	55.4609
2025	11	23	3	52	15	24.08	96.9	7.0555	56.4049
2025	11	23	4	2	15	23.92	95.8	7.0555	56.1689
2025	11	23	4	12	15	25.15	93.6	7.0555	59.237
2025	11	23	4	22	15	23.73	98	7.0555	55.4609
2025	11	23	4	32	15	25.12	97.5	7.0555	58.765
2025	11	23	4	42	15	24.76	98.4	7.0555	57.8209
2025	11	23	4	52	15	25.21	95.5	7.0494	59.1834
2025	11	23	5	2	15	25.9	97.1	7.0494	60.5982
2025	11	23	5	12	15	23.93	96	7.0555	56.1689
2025	11	23	5	22	15	24.31	95.4	7.0494	57.0613
2025	11	23	5	32	15	23.81	95.5	7.0494	55.8824
2025	11	23	5	42	15	24.97	96.7	7.0494	58.4761
2025	11	23	5	52	15	24.45	96.3	7.0494	57.2971
2025	11	23	6	2	15	24.42	95.6	7.0494	57.2972
2025	11	23	6	12	15	24.29	95	7.0494	57.0614
2025	11	23	6	22	15	24.78	94.6	7.0494	58.2403
2025	11	23	6	32	15	23.92	95.8	7.0494	56.1182
2025	11	23	6	42	15	24.06	98.4	7.0494	56.1182
2025	11	23	6	52	15	24.77	94.2	7.0494	58.2403
2025	11	23	7	2	15	23.77	94.3	7.0494	55.8824
2025	11	23	7	12	15	24.69	94.9	7.0494	58.0046
2025	11	23	7	22	15	25.47	96.5	7.0494	59.6551
2025	11	23	7	32	15	25.32	95.7	7.0494	59.4193
2025	11	23	7	42	15	25.07	96.6	7.0494	58.712
2025	11	23	7	52	15	24.23	95.9	7.0433	56.7742

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	23	8	2	15	23.85	93.8	7.0433	56.0675
2025	11	23	8	12	15	25.32	97.5	7.0433	59.13
2025	11	23	8	22	15	24.47	96.8	7.0433	57.2454
2025	11	23	8	32	15	26.04	96	7.0433	61.0146
2025	11	23	8	42	15	25.51	97.4	7.0433	59.6012
2025	11	23	8	52	15	25.17	98.5	7.0372	58.6058
2025	11	23	9	2	15	24.44	98	7.0433	57.0098
2025	11	23	9	12	15	24.98	98.5	7.0433	58.1877
2025	11	23	9	22	15	22.94	93.2	7.0372	53.8984
2025	11	23	9	32	15	24.98	96.9	7.0372	58.3703
2025	11	23	9	42	15	25.84	97.8	7.0372	60.2532
2025	11	23	9	52	15	24.14	98.1	7.0311	56.201
2025	11	23	10	2	15	24.18	98.8	7.0311	56.201
2025	11	23	10	12	15	24.76	98.4	7.0311	57.6119
2025	11	23	10	22	15	25.61	95.4	7.0311	59.9634
2025	11	23	10	32	15	25.08	96.9	7.025	58.4994
2025	11	23	10	42	15	23.83	98	7.025	55.4452
2025	11	23	10	52	15	23.28	97.2	7.025	54.2705
2025	11	23	11	2	15	24.92	99.2	7.025	57.7945
2025	11	23	11	12	15	24.56	99.8	7.025	56.8547
2025	11	23	11	22	15	24.3	100.4	7.025	56.1499
2025	11	23	11	32	15	23.98	96.9	7.0189	55.8642
2025	11	23	11	42	15	23.65	98.3	7.025	54.9752
2025	11	23	11	52	15	24.87	96.7	7.0189	57.9766
2025	11	23	12	2	15	23.4	95.4	7.0189	54.6905
2025	11	23	12	12	15	22.74	96.3	7.0189	53.0474
2025	11	23	12	22	15	22.6	97.6	7.0189	52.5779
2025	11	23	12	32	15	22.45	96.7	7.0189	52.3432
2025	11	23	12	42	15	23.93	97.9	7.0189	55.6293
2025	11	23	12	52	15	22.85	98.6	7.0189	53.0473
2025	11	23	13	2	15	24.28	101.4	7.0189	55.864
2025	11	23	13	12	15	23.52	97.8	7.0189	54.6904
2025	11	23	13	22	15	25.04	96	7.0189	58.4459
2025	11	23	13	32	15	23.2	95.2	7.0189	54.2209
2025	11	23	13	42	15	23.22	97.9	7.0189	53.9862
2025	11	23	13	52	15	24.03	96	7.0189	56.0986
2025	11	23	14	2	15	24.76	96.5	7.0189	57.7417
2025	11	23	14	12	15	24.42	97.8	7.0189	56.8028
2025	11	23	14	22	15	25.57	98.3	7.0189	59.3847
2025	11	23	14	32	15	24.09	98.8	7.0189	55.8639
2025	11	23	14	42	15	24.17	96.9	7.0128	56.2822
2025	11	23	14	52	15	25.21	95.5	7.0128	58.8617
2025	11	23	15	2	15	23.31	97.6	7.0189	54.2208
2025	11	23	15	12	15	24.73	95.8	7.0189	57.7417
2025	11	23	15	22	15	24.3	95.2	7.0189	56.8028
2025	11	23	15	32	15	24.62	95.6	7.0128	57.4547
2025	11	23	15	42	15	24.01	97.7	7.0189	55.8639
2025	11	23	15	52	15	24.54	96.1	7.0128	57.2202

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	23	16	2	15	25.57	96.5	7.0128	59.5653
2025	11	23	16	12	15	25.03	95.7	7.0128	58.3928
2025	11	23	16	22	15	24.82	99.3	7.0128	57.4547
2025	11	23	16	32	15	25.99	96.9	7.0128	60.5034
2025	11	23	16	42	15	24.97	96.7	7.0128	58.1583
2025	11	23	16	52	15	24.08	96.9	7.0128	56.0477
2025	11	23	17	2	15	25.23	97.7	7.0128	58.6273
2025	11	23	17	12	15	25.63	99.2	7.0128	59.3308
2025	11	23	17	22	15	23.6	97.5	7.0128	54.8751
2025	11	23	17	32	15	23.83	96	7.0128	55.5787
2025	11	23	17	42	15	24.13	95.9	7.0128	56.2822
2025	11	23	17	52	15	23.93	97.9	7.0128	55.5787
2025	11	23	18	2	15	24.55	98.2	7.0067	56.9339
2025	11	23	18	12	15	23.93	97.9	7.0067	55.5281
2025	11	23	18	22	15	24.37	96.8	7.0067	56.6996
2025	11	23	18	32	15	24.03	96	7.0067	55.9967
2025	11	23	18	42	15	24.86	96.5	7.0067	57.8711
2025	11	23	18	52	15	24.78	97	7.0067	57.6368
2025	11	23	19	2	15	24.06	98.4	7.0067	55.7625
2025	11	23	19	12	15	24.27	96.9	7.0067	56.4654
2025	11	23	19	22	15	25.86	96.4	7.0067	60.2141
2025	11	23	19	32	15	25.13	97.8	7.0006	58.2867
2025	11	23	19	42	15	25.3	97.3	7.0006	58.7549
2025	11	23	19	52	15	25.5	97.2	7.0006	59.2231
2025	11	23	20	2	15	25.42	97.5	7.0006	58.989
2025	11	23	20	12	15	24.27	96.9	7.0006	56.4141
2025	11	23	20	22	15	23.35	99.9	7.0006	53.8392
2025	11	23	20	32	15	24.62	97.7	7.0006	57.1164
2025	11	23	20	42	15	25.3	97.3	7.0006	58.755
2025	11	23	20	52	15	24.29	95	7.0006	56.6482
2025	11	23	21	2	15	25.81	95.3	7.0006	60.1595
2025	11	23	21	12	15	24.92	97.6	7.0006	57.8187
2025	11	23	21	22	15	24.89	98.8	7.0006	57.5846
2025	11	23	21	32	15	25.66	96.5	7.0006	59.6914
2025	11	23	21	42	15	24.19	95	6.9945	56.3628
2025	11	23	21	52	15	24.48	97	6.9945	56.8306
2025	11	23	22	2	15	24.97	96.7	6.9945	58
2025	11	23	22	12	15	24.77	96.7	6.9945	57.5323
2025	11	23	22	22	15	24.77	96.7	6.9945	57.5323
2025	11	23	22	32	15	23.86	96.7	6.9945	55.4275
2025	11	23	22	42	15	24.86	96.5	6.9945	57.7662
2025	11	23	22	52	15	25.38	96.8	6.9945	58.9356
2025	11	23	23	2	15	24.29	97.1	6.9945	56.363
2025	11	23	23	12	15	24.01	97.7	6.9945	55.6614
2025	11	23	23	22	15	25.02	95.5	6.9945	58.234
2025	11	23	23	32	15	24.85	98.1	6.9945	57.5324
2025	11	23	23	42	15	25.81	97.3	6.9945	59.8712
2025	11	23	23	52	15	25.37	96.6	6.9945	58.9357

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	24	0	2	15	25.8	98.7	6.9885	59.5829
2025	11	24	0	12	15	25.37	96.6	6.9885	58.882
2025	11	24	0	22	15	25.03	95.7	6.9885	58.181
2025	11	24	0	32	15	25.19	97.1	6.9885	58.4147
2025	11	24	0	42	15	24.13	97.9	6.9885	55.8445
2025	11	24	0	52	15	24.93	97.8	6.9885	57.7138
2025	11	24	1	2	15	24.16	96.7	6.9885	56.0782
2025	11	24	1	12	15	25.01	97.4	6.9885	57.9474
2025	11	24	1	22	15	24.22	95.7	6.9885	56.3118
2025	11	24	1	32	15	24.45	99.7	6.9824	56.2605
2025	11	24	1	42	15	25	95	6.9885	58.1811
2025	11	24	1	52	15	25.32	97.5	6.9885	58.6485
2025	11	24	2	2	15	25.36	96.3	6.9824	58.8284
2025	11	24	2	12	15	24.37	96.8	6.9824	56.4939
2025	11	24	2	22	15	24.46	96.6	6.9824	56.7274
2025	11	24	2	32	15	24.44	98	6.9824	56.4939
2025	11	24	2	42	15	25.27	98.4	6.9824	58.3615
2025	11	24	2	52	15	25.33	99.3	6.9824	58.3615
2025	11	24	3	2	15	24.38	98.7	6.9824	56.2605
2025	11	24	3	12	15	24.65	98.2	6.9824	56.9609
2025	11	24	3	22	15	24.25	99.7	6.9763	55.7427
2025	11	24	3	32	15	24.5	98.9	6.9763	56.4424
2025	11	24	3	42	15	26.1	97	6.9763	60.4073
2025	11	24	3	52	15	25.02	99.2	6.9763	57.6085
2025	11	24	4	2	15	24.99	98.7	6.9763	57.6085
2025	11	24	4	12	15	24.82	97.6	6.9763	57.3753
2025	11	24	4	22	15	25.14	98	6.9763	58.075
2025	11	24	4	32	15	26.49	96.9	6.9763	61.3403
2025	11	24	4	42	15	24.92	97.6	6.9763	57.6086
2025	11	24	4	52	15	23.69	99	6.9763	54.5765
2025	11	24	5	2	15	24.38	98.7	6.9763	56.2092
2025	11	24	5	12	15	24.79	97.2	6.9763	57.3753
2025	11	24	5	22	15	25.71	97.4	6.9763	59.4744
2025	11	24	5	32	15	24.62	97.7	6.9702	56.8568
2025	11	24	5	42	15	24.23	97.8	6.9702	55.9248
2025	11	24	5	52	15	25.07	99.9	6.9702	57.5559
2025	11	24	6	2	15	24.76	98.4	6.9702	57.0899
2025	11	24	6	12	15	24.09	98.8	6.9702	55.4587
2025	11	24	6	22	15	24.37	96.8	6.9702	56.3908
2025	11	24	6	32	15	25.36	98.2	6.9702	58.488
2025	11	24	6	42	15	24.76	96.5	6.9702	57.3229
2025	11	24	6	52	15	23.74	99.7	6.9641	54.4768
2025	11	24	7	2	15	25.2	97.3	6.9702	58.255
2025	11	24	7	12	15	24.81	99	6.9702	57.0899
2025	11	24	7	22	15	23.9	97.5	6.9702	55.2258
2025	11	24	7	32	15	25.07	99.9	6.9641	57.5033
2025	11	24	7	42	15	24.03	97.9	6.9702	55.4588
2025	11	24	7	52	15	24.81	99	6.9702	57.0899

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	24	8	2	15	24.12	99.3	6.9702	55.4588
2025	11	24	8	12	15	22.51	99.5	6.9641	51.6831
2025	11	24	8	22	15	25.15	99.6	6.9641	57.7361
2025	11	24	8	32	15	24.12	99.3	6.958	55.3573
2025	11	24	8	42	15	24.53	99.4	6.958	56.2876
2025	11	24	8	52	15	24.03	97.9	6.958	55.3573
2025	11	24	9	2	15	24.12	99.3	6.9641	55.408
2025	11	24	9	12	15	23.33	98.1	6.9641	53.7783
2025	11	24	9	22	15	24.48	94.7	6.9641	56.8048
2025	11	24	9	32	15	24.53	99.4	6.958	56.2876
2025	11	24	9	42	15	23.7	97.5	6.958	54.6594
2025	11	24	9	52	15	24.04	98.1	6.9519	55.3064
2025	11	24	10	2	15	23.83	100.9	6.9519	54.3768
2025	11	24	10	12	15	25.48	98.6	6.9519	58.5597
2025	11	24	10	22	15	25.04	99.4	6.9519	57.3977
2025	11	24	10	32	15	23.44	99.8	6.9458	53.6304
2025	11	24	10	42	15	23.48	98.8	6.9458	53.8625
2025	11	24	10	52	15	23.59	99	6.9458	54.0947
2025	11	24	11	2	15	24.7	100.3	6.9458	56.4163
2025	11	24	11	12	15	22.8	99.3	6.9519	52.2853
2025	11	24	11	22	15	23.59	99	6.9458	54.0946
2025	11	24	11	32	15	23.44	99.8	6.9458	53.6302
2025	11	24	11	42	15	24.13	97.9	6.9519	55.5385
2025	11	24	11	52	15	23.04	98.2	6.9519	52.9823
2025	11	24	12	2	15	24.38	98.7	6.9519	56.0032
2025	11	24	12	12	15	24.86	99.7	6.9519	56.9327
2025	11	24	12	22	15	23.35	98.4	6.9519	53.6794
2025	11	24	12	32	15	23.02	99.5	6.9519	52.7498
2025	11	24	12	42	15	24.89	100.2	6.9519	56.9326
2025	11	24	12	52	15	24.73	97.9	6.9458	56.8804
2025	11	24	13	2	15	23.4	95.4	6.9519	54.1441
2025	11	24	13	12	15	24.66	98.4	6.9519	56.7002
2025	11	24	13	22	15	25.46	98.1	6.9519	58.5592
2025	11	24	13	32	15	24.73	97.9	6.9458	56.8803
2025	11	24	13	42	15	25.71	98.9	6.9458	58.9698
2025	11	24	13	52	15	25.3	97.3	6.9458	58.2733
2025	11	24	14	2	15	24.22	99.3	6.9458	55.4873
2025	11	24	14	12	15	24.3	97.3	6.9458	55.9516
2025	11	24	14	22	15	24.2	95.2	6.9458	55.9516
2025	11	24	14	32	15	25.49	97	6.9397	58.6836
2025	11	24	14	42	15	24.7	97.2	6.9397	56.828
2025	11	24	14	52	15	23.4	95.4	6.9458	54.0943
2025	11	24	15	2	15	23.38	98.9	6.9397	53.5807
2025	11	24	15	12	15	25.07	96.6	6.9397	57.7558
2025	11	24	15	22	15	23.99	97.2	6.9397	55.2043
2025	11	24	15	32	15	24.37	94.5	6.9397	56.3641
2025	11	24	15	42	15	23.88	97	6.9397	54.9724
2025	11	24	15	52	15	24.72	97.7	6.9397	56.828

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	24	16	2	15	25.24	99.4	6.9397	57.7558
2025	11	24	16	12	15	23.17	94.5	6.9397	53.5807
2025	11	24	16	22	15	24.68	98.6	6.9397	56.5961
2025	11	24	16	32	15	24.42	97.8	6.9397	56.1322
2025	11	24	16	42	15	26.12	99	6.9458	59.8985
2025	11	24	16	52	15	24.62	97.7	6.9458	56.6482
2025	11	24	17	2	15	23.48	98.8	6.9458	53.8622
2025	11	24	17	12	15	23.87	100.1	6.9458	54.5587
2025	11	24	17	22	15	24.35	98.3	6.9458	55.9517
2025	11	24	17	32	15	23.83	98	6.9397	54.7405
2025	11	24	17	42	15	24.3	100.4	6.9397	55.4364
2025	11	24	17	52	15	24.82	97.6	6.9397	57.0601
2025	11	24	18	2	15	24.23	97.8	6.9397	55.6684
2025	11	24	18	12	15	25.1	97.3	6.9397	57.7559
2025	11	24	18	22	15	23.48	97.1	6.9397	54.0447
2025	11	24	18	32	15	24.68	98.6	6.9397	56.5962
2025	11	24	18	42	15	25.5	98.8	6.9397	58.4518
2025	11	24	18	52	15	23.93	97.9	6.9397	54.9726
2025	11	24	19	2	15	23.95	96.5	6.9397	55.2046
2025	11	24	19	12	15	24.97	96.7	6.9397	57.5241
2025	11	24	19	22	15	24.99	97.1	6.9397	57.5241
2025	11	24	19	32	15	24.25	96.4	6.9397	55.9005
2025	11	24	19	42	15	24.83	95.8	6.9397	57.2922
2025	11	24	19	52	15	24.51	95.4	6.9397	56.5964
2025	11	24	20	2	15	25.08	96.9	6.9336	57.703
2025	11	24	20	12	15	22.39	97.4	6.9336	51.4461
2025	11	24	20	22	15	23.53	96.1	6.9336	54.227
2025	11	24	20	32	15	23.16	96.7	6.9336	53.3001
2025	11	24	20	42	15	23.99	97.2	6.9336	55.154
2025	11	24	20	52	15	24.03	96	6.9336	55.3858
2025	11	24	21	2	15	24.2	95.2	6.9336	55.8493
2025	11	24	21	12	15	23.49	95.1	6.9336	54.2271
2025	11	24	21	22	15	25.14	98	6.9336	57.7033
2025	11	24	21	32	15	23.73	96	6.9336	54.6907
2025	11	24	21	42	15	26	97.1	6.9336	59.789
2025	11	24	21	52	15	24.76	96.5	6.9336	57.0081
2025	11	24	22	2	15	24.42	95.6	6.9336	56.3129
2025	11	24	22	12	15	24.32	95.7	6.9336	56.0812
2025	11	24	22	22	15	23.99	97.2	6.9275	55.1035
2025	11	24	22	32	15	24.23	97.8	6.9275	55.5666
2025	11	24	22	42	15	25.71	97.4	6.9275	59.0395
2025	11	24	22	52	15	23.49	94.9	6.9275	54.1775
2025	11	24	23	2	15	24.22	95.7	6.9275	55.7982
2025	11	24	23	12	15	25.41	95.4	6.9275	58.5766
2025	11	24	23	22	15	24.41	97.5	6.9275	56.0298
2025	11	24	23	32	15	24.17	96.9	6.9275	55.5667
2025	11	24	23	42	15	25.7	97.2	6.9275	59.0397
2025	11	24	23	52	15	24.13	97.9	6.9275	55.3353

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	25	0	2	15	24.83	97.9	6.9275	56.956
2025	11	25	0	12	15	25.87	96.7	6.9275	59.5028
2025	11	25	0	22	15	25.08	96.9	6.9275	57.6506
2025	11	25	0	32	15	24.85	96.2	6.9275	57.1876
2025	11	25	0	42	15	25.76	96.5	6.9214	59.2168
2025	11	25	0	52	15	25.1	97.3	6.9214	57.5976
2025	11	25	1	2	15	25.4	97.2	6.9275	58.3453
2025	11	25	1	12	15	24.63	95.8	6.9214	56.6723
2025	11	25	1	22	15	26.38	98.3	6.9214	60.3734
2025	11	25	1	32	15	25.03	95.7	6.9214	57.5976
2025	11	25	1	42	15	25.19	94.8	6.9214	58.0603
2025	11	25	1	52	15	26.05	97.9	6.9214	59.6795
2025	11	25	2	2	15	25.06	96.4	6.9214	57.5977
2025	11	25	2	12	15	25.03	95.7	6.9214	57.5977
2025	11	25	2	22	15	25.03	97.8	6.9214	57.3663
2025	11	25	2	32	15	24.6	97.2	6.9214	56.4411
2025	11	25	2	42	15	23.82	97.7	6.9214	54.5906
2025	11	25	2	52	15	24.67	96.8	6.9214	56.6724
2025	11	25	3	2	15	24.66	98.4	6.9214	56.4411
2025	11	25	3	12	15	24.62	95.6	6.9214	56.6724
2025	11	25	3	22	15	24.66	96.5	6.9214	56.6724
2025	11	25	3	32	15	25.17	98.5	6.9214	57.5977
2025	11	25	3	42	15	24.67	96.8	6.9214	56.6724
2025	11	25	3	52	15	23.77	96.8	6.9214	54.5906
2025	11	25	4	2	15	25.22	97.5	6.9214	57.829
2025	11	25	4	12	15	23.21	99.4	6.9214	52.9714
2025	11	25	4	22	15	25.33	99.3	6.9153	57.7757
2025	11	25	4	32	15	24.25	96.4	6.9214	55.7472
2025	11	25	4	42	15	25.5	97.2	6.9214	58.523
2025	11	25	4	52	15	23.62	97.8	6.9214	54.128
2025	11	25	5	2	15	23.26	96.7	6.9153	53.3848
2025	11	25	5	12	15	23.77	96.8	6.9214	54.5906
2025	11	25	5	22	15	24.83	95.8	6.9214	57.1351
2025	11	25	5	32	15	24.75	98.1	6.9153	56.6202
2025	11	25	5	42	15	23.89	98.9	6.9153	54.5403
2025	11	25	5	52	15	24.65	96.3	6.9214	56.6724
2025	11	25	6	2	15	24.31	97.6	6.9153	55.6958
2025	11	25	6	12	15	24.21	95.5	6.9153	55.6958
2025	11	25	6	22	15	24.32	95.7	6.9153	55.9269
2025	11	25	6	32	15	24.22	95.7	6.9153	55.6958
2025	11	25	6	42	15	23.21	97.7	6.9153	53.1537
2025	11	25	6	52	15	24.54	98	6.9153	56.158
2025	11	25	7	2	15	24.24	98.1	6.9153	55.4647
2025	11	25	7	12	15	24.51	97.5	6.9153	56.158
2025	11	25	7	22	15	24.88	96.9	6.9153	57.0824
2025	11	25	7	32	15	26.15	97.9	6.9153	59.8557
2025	11	25	7	42	15	24.73	99.3	6.9153	56.3891
2025	11	25	7	52	15	24.03	96	6.9153	55.2336

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	25	8	2	15	24.99	97.1	6.9153	57.3135
2025	11	25	8	12	15	25.16	98.2	6.9153	57.5446
2025	11	25	8	22	15	22.94	96.3	6.9153	52.6915
2025	11	25	8	32	15	24.09	98.8	6.9153	55.0025
2025	11	25	8	42	15	22.09	97.5	6.9153	50.6115
2025	11	25	8	52	15	24.81	100.4	6.9092	56.3371
2025	11	25	9	2	15	25.1	98.9	6.9092	57.2606
2025	11	25	9	12	15	23.05	98.5	6.9153	52.6914
2025	11	25	9	22	15	23.69	99	6.9153	54.078
2025	11	25	9	32	15	24.36	96.6	6.9092	55.8752
2025	11	25	9	42	15	23.21	97.7	6.9153	53.1536
2025	11	25	9	52	15	23.43	98.1	6.9153	53.6157
2025	11	25	10	2	15	23.92	95.8	6.9153	55.0023
2025	11	25	10	12	15	23.18	97.2	6.9153	53.1535
2025	11	25	10	22	15	23.35	96.4	6.9153	53.6157
2025	11	25	10	32	15	22.91	97.8	6.9153	52.4601
2025	11	25	10	42	15	23.96	98.4	6.9153	54.7711
2025	11	25	10	52	15	24.03	96	6.9153	55.2333
2025	11	25	11	2	15	24.2	97.4	6.9153	55.4644
2025	11	25	11	12	15	23.1	97.5	6.9153	52.9222
2025	11	25	11	22	15	21.82	98.2	6.9153	49.9179
2025	11	25	11	32	15	22.83	98.1	6.9153	52.2289
2025	11	25	11	42	15	23.43	98.1	6.9153	53.6154
2025	11	25	11	52	15	23.52	97.8	6.9153	53.8465
2025	11	25	12	2	15	23.18	97.2	6.9153	53.1532
2025	11	25	12	12	15	24.02	99.3	6.9153	54.7709
2025	11	25	12	28	1	24.03	97.9	6.9153	55.002
2025	11	25	12	38	1	24.04	101	6.9153	54.5397
2025	11	25	12	48	1	23	97.5	6.9153	52.6909
2025	11	25	12	58	1	23.28	98.9	6.9153	53.1531
2025	11	25	13	8	1	23.48	97.1	6.9153	53.8464
2025	11	25	13	18	1	25.32	97.5	6.9153	58.0062
2025	11	25	13	28	1	23.1	99.2	6.9153	52.6909
2025	11	25	13	38	1	23.39	99.1	6.9153	53.3841
2025	11	25	13	48	1	24.09	98.8	6.9153	55.0018
2025	11	25	13	58	1	23.68	97	6.9153	54.3085
2025	11	25	14	8	1	24.86	96.5	6.9153	57.0817
2025	11	25	14	18	1	23.32	95.9	6.9153	53.6152
2025	11	25	14	28	1	23.65	96.6	6.9153	54.3085
2025	11	25	14	38	1	23.16	94.2	6.9153	53.3841
2025	11	25	14	48	1	23.9	97.5	6.9153	54.7707
2025	11	25	14	58	1	23.56	98.5	6.9153	53.8463
2025	11	25	15	8	1	23.72	99.5	6.9153	54.0774
2025	11	25	15	18	1	23.93	97.9	6.9153	54.7707
2025	11	25	15	28	1	24.73	97.9	6.9153	56.6195
2025	11	25	15	38	1	23.48	100.3	6.9153	53.3841
2025	11	25	15	48	1	25.04	99.4	6.9153	57.0817
2025	11	25	15	58	1	24	99.1	6.9153	54.7707

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	25	16	8	1	25.83	101.6	6.9153	58.4684
2025	11	25	16	18	1	24.53	99.4	6.9153	55.9263
2025	11	25	16	28	1	24.18	98.8	6.9153	55.233
2025	11	25	16	38	1	24.22	95.7	6.9153	55.6952
2025	11	25	16	48	1	24.07	98.6	6.9153	55.0019
2025	11	25	16	58	1	23.52	97.8	6.9153	53.8464
2025	11	25	17	8	1	24.96	98.3	6.9092	57.0291
2025	11	25	17	18	1	23.72	99.5	6.9153	54.0775
2025	11	25	17	28	1	24.42	97.8	6.9153	55.9263
2025	11	25	17	38	1	23.64	96.3	6.9153	54.3086
2025	11	25	17	48	1	24.45	98.2	6.9092	55.8747
2025	11	25	17	58	1	24.2	99	6.9153	55.2331
2025	11	25	18	8	1	23.97	98.6	6.9092	54.7203
2025	11	25	18	18	1	25.15	96.2	6.9092	57.7219
2025	11	25	18	28	1	22.69	97.3	6.9153	51.9977
2025	11	25	18	38	1	24.78	94.6	6.9153	57.0819
2025	11	25	18	48	1	24.78	97	6.9092	56.7984
2025	11	25	18	58	1	23.43	96.1	6.9092	53.7969
2025	11	25	19	8	1	23.69	99	6.9092	54.0278
2025	11	25	19	18	1	23.08	97.2	6.9092	52.8733
2025	11	25	19	28	1	25.55	96.3	6.9092	58.6456
2025	11	25	19	38	1	24.92	97.6	6.9092	57.0294
2025	11	25	19	48	1	23.7	95.3	6.9092	54.4896
2025	11	25	19	58	1	23.78	94.8	6.9092	54.7205
2025	11	25	20	8	1	23.7	95.3	6.9092	54.4897
2025	11	25	20	18	1	25.57	98.3	6.9092	58.4148
2025	11	25	20	28	1	22.96	96.8	6.9092	52.6426
2025	11	25	20	38	1	23.91	95.5	6.9092	54.9515
2025	11	25	20	48	1	24.23	95.9	6.9092	55.6442
2025	11	25	20	58	1	24.54	98	6.9031	56.0542
2025	11	25	21	8	1	25.87	96.7	6.9031	59.2837
2025	11	25	21	18	1	23.82	95.8	6.9031	54.6702
2025	11	25	21	28	1	23.68	97	6.9031	54.2089
2025	11	25	21	38	1	24.65	93.7	6.9031	56.7463
2025	11	25	21	48	1	24.33	95.9	6.9031	55.8237
2025	11	25	21	58	1	25.6	100.1	6.9031	58.1304
2025	11	25	22	8	1	24.83	97.9	6.9031	56.7464
2025	11	25	22	18	1	23.83	98	6.9031	54.4397
2025	11	25	22	28	1	24.79	98.8	6.9031	56.5158
2025	11	25	22	38	1	24.2	97.4	6.9031	55.3624
2025	11	25	22	48	1	24.91	97.4	6.9031	56.9772
2025	11	25	22	58	1	24.76	99.8	6.9031	56.2852
2025	11	25	23	8	1	24.82	99.3	6.9031	56.5159
2025	11	25	23	18	1	23.77	98.7	6.9031	54.2091
2025	11	25	23	28	1	24.36	101.1	6.9031	55.1319
2025	11	25	23	38	1	24.33	99.5	6.9031	55.3626
2025	11	25	23	48	1	24.3	99	6.9031	55.3626
2025	11	25	23	58	1	23.99	98.9	6.9031	54.6706

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	26	0	8	1	24.91	100.4	6.9031	56.516
2025	11	26	0	18	1	23.68	100.2	6.897	53.6982
2025	11	26	0	28	1	23.69	101.7	6.9031	53.5172
2025	11	26	0	38	1	23.18	100.4	6.9031	52.5945
2025	11	26	0	48	1	23.85	101.1	6.9031	53.9786
2025	11	26	0	58	1	23.53	98.1	6.897	53.6983
2025	11	26	1	8	1	24.06	96.7	6.897	55.0811
2025	11	26	1	18	1	24.34	98	6.897	55.542
2025	11	26	1	28	1	23.05	100	6.897	52.3155
2025	11	26	1	38	1	22.95	96.5	6.897	52.546
2025	11	26	1	48	1	23.39	99.1	6.897	53.2374
2025	11	26	1	58	1	24.86	96.5	6.897	56.9249
2025	11	26	2	8	1	24.28	101.4	6.897	54.8507
2025	11	26	2	18	1	24.76	99.8	6.897	56.2335
2025	11	26	2	28	1	23.97	100.1	6.897	54.3898
2025	11	26	2	38	1	23.49	99.1	6.897	53.4679
2025	11	26	2	48	1	23.62	99.5	6.897	53.6984
2025	11	26	2	58	1	23.76	98.5	6.897	54.1593
2025	11	26	3	8	1	24.37	98.5	6.897	55.5421
2025	11	26	3	18	1	24.45	98.2	6.897	55.7726
2025	11	26	3	28	1	23.69	99	6.897	53.9289
2025	11	26	3	38	1	25.33	97.7	6.897	57.8468
2025	11	26	3	48	1	24.17	98.6	6.897	55.0812
2025	11	26	3	58	1	25.36	98.2	6.897	57.8468
2025	11	26	4	8	1	24.13	99.5	6.897	54.8507
2025	11	26	4	18	1	25.04	99.4	6.897	56.9249
2025	11	26	4	28	1	25.09	98.7	6.897	57.1554
2025	11	26	4	38	1	23.39	97.4	6.897	53.4679
2025	11	26	4	48	1	24.5	97.3	6.897	56.0031
2025	11	26	4	58	1	23.36	96.6	6.897	53.4679
2025	11	26	5	8	1	24.35	99.7	6.897	55.3117
2025	11	26	5	18	1	23.46	100.1	6.897	53.2375
2025	11	26	5	28	1	23.94	96.2	6.897	54.8507
2025	11	26	5	38	1	24.61	100.5	6.897	55.7726
2025	11	26	5	48	1	23.35	98.4	6.897	53.2375
2025	11	26	5	58	1	24.52	100.6	6.897	55.5421
2025	11	26	6	8	1	23.85	99.9	6.897	54.1593
2025	11	26	6	18	1	24.52	97.7	6.897	56.0031
2025	11	26	6	28	1	24.35	99.7	6.897	55.3117
2025	11	26	6	38	1	23.82	97.7	6.897	54.3898
2025	11	26	6	48	1	24.71	99.1	6.897	56.2335
2025	11	26	6	58	1	23.63	98	6.897	53.9289
2025	11	26	7	8	1	24.11	97.6	6.897	55.0812
2025	11	26	7	18	1	24.95	98.1	6.897	56.9249
2025	11	26	7	28	1	24.79	98.8	6.897	56.464
2025	11	26	7	38	1	23.42	97.9	6.897	53.468
2025	11	26	7	48	1	25.29	98.6	6.897	57.6163
2025	11	26	7	58	1	23.49	99.1	6.897	53.4679

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	26	8	8	1	24.3	99	6.897	55.3117
2025	11	26	8	18	1	23.31	99.4	6.897	53.007
2025	11	26	8	28	1	24.38	100.2	6.897	55.3117
2025	11	26	8	38	1	23.76	98.5	6.897	54.1593
2025	11	26	8	48	1	24.3	97.3	6.897	55.5421
2025	11	26	8	58	1	23.31	97.6	6.897	53.2374
2025	11	26	9	8	1	23.32	97.9	6.897	53.2374
2025	11	26	9	18	1	23.68	98.7	6.897	53.9288
2025	11	26	9	28	1	24.13	99.5	6.897	54.8507
2025	11	26	9	38	1	23.74	99.7	6.897	53.9288
2025	11	26	9	48	1	24.23	99.5	6.897	55.0811
2025	11	26	9	58	1	24.95	98.1	6.897	56.9248
2025	11	26	10	8	1	25.02	99.2	6.897	56.9247
2025	11	26	10	18	1	24.12	102	6.897	54.3896
2025	11	26	10	28	1	24.07	98.6	6.897	54.8505
2025	11	26	10	38	1	23.59	99	6.897	53.6981
2025	11	26	10	48	1	23.91	100.6	6.897	54.159
2025	11	26	10	58	1	23.21	99.4	6.897	52.7762
2025	11	26	11	8	1	24.22	99.3	6.897	55.0808
2025	11	26	11	18	1	23.52	100.8	6.897	53.2371
2025	11	26	11	28	1	23.95	99.9	6.9031	54.4397
2025	11	26	11	38	1	23.63	98	6.9031	53.9783
2025	11	26	11	48	1	24.28	98.8	6.9031	55.3624
2025	11	26	11	58	1	24.03	97.9	6.9031	54.901
2025	11	26	12	8	1	24.25	98.3	6.9031	55.3623
2025	11	26	12	18	1	24.67	101.2	6.9031	55.8236
2025	11	26	12	28	1	24.78	98.6	6.9031	56.5156
2025	11	26	12	38	1	24.68	97	6.9031	56.5156
2025	11	26	12	48	1	23.69	99	6.9031	53.9782
2025	11	26	12	58	1	24.34	98	6.9031	55.5929
2025	11	26	13	8	1	24.58	98.7	6.9031	56.0542
2025	11	26	13	18	1	23.43	98.1	6.9031	53.5168
2025	11	26	13	28	1	23.21	99.4	6.9031	52.8247
2025	11	26	13	38	1	23.53	98.1	6.9031	53.7474
2025	11	26	13	48	1	23.99	98.9	6.9031	54.6701
2025	11	26	13	58	1	23.73	98	6.9031	54.2087
2025	11	26	14	8	1	22.95	98.5	6.9031	52.3633
2025	11	26	14	18	1	24.22	95.7	6.9031	55.5928
2025	11	26	14	28	1	24.05	99.8	6.9031	54.6701
2025	11	26	14	38	1	23.17	96.9	6.9031	53.0553
2025	11	26	14	48	1	23.85	96.5	6.9031	54.6701
2025	11	26	14	58	1	23.79	98.9	6.9031	54.2087
2025	11	26	15	8	1	23.96	98.4	6.9031	54.6701
2025	11	26	15	18	1	23.62	97.8	6.9031	53.978
2025	11	26	15	28	1	23.89	95	6.9031	54.9007
2025	11	26	15	38	1	23.89	97.2	6.9031	54.6701
2025	11	26	15	48	1	23.53	98.1	6.9031	53.7474
2025	11	26	15	58	1	23.67	96.8	6.9031	54.2087

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	26	16	8	1	24.13	97.9	6.9031	55.1315
2025	11	26	16	18	1	23.38	97.1	6.9031	53.5167
2025	11	26	16	28	1	24.11	97.6	6.9031	55.1315
2025	11	26	16	38	1	23.42	95.9	6.9031	53.7474
2025	11	26	16	48	1	23.2	95.4	6.9031	53.2861
2025	11	26	16	58	1	23.88	97	6.9031	54.6702
2025	11	26	17	8	1	24	99.1	6.9031	54.6702
2025	11	26	17	18	1	24.99	97.1	6.9031	57.2076
2025	11	26	17	28	1	24.03	96	6.9031	55.1315
2025	11	26	17	38	1	23.29	95.2	6.9031	53.5168
2025	11	26	17	48	1	24.75	98.1	6.9031	56.5156
2025	11	26	17	58	1	23.92	95.8	6.9031	54.9009
2025	11	26	18	8	1	22.61	97.9	6.9031	51.6714
2025	11	26	18	18	1	24.05	96.4	6.9031	55.1316
2025	11	26	18	28	1	23.31	95.7	6.9031	53.5169
2025	11	26	18	38	1	23.41	97.6	6.9031	53.5169
2025	11	26	18	48	1	24.54	98	6.9031	56.0543
2025	11	26	18	58	1	24.92	95.5	6.9031	57.2077
2025	11	26	19	8	1	24.5	98.9	6.9031	55.8237
2025	11	26	19	18	1	24.13	97.9	6.9031	55.1317
2025	11	26	19	28	1	23.96	98.4	6.9031	54.6704
2025	11	26	19	38	1	23.42	97.9	6.897	53.4675
2025	11	26	19	48	1	23.43	98.1	6.9031	53.517
2025	11	26	19	58	1	23.17	100.2	6.9031	52.5943
2025	11	26	20	8	1	24.09	98.8	6.897	54.8504
2025	11	26	20	18	1	23.77	96.8	6.9031	54.4398
2025	11	26	20	28	1	23.93	97.9	6.9031	54.6705
2025	11	26	20	38	1	24.42	95.6	6.9031	56.0546
2025	11	26	20	48	1	24.77	96.7	6.9031	56.7466
2025	11	26	20	58	1	24.47	98.5	6.9031	55.824
2025	11	26	21	8	1	24.51	97.5	6.897	56.0028
2025	11	26	21	18	1	24.21	97.6	6.897	55.3115
2025	11	26	21	28	1	23.87	100.1	6.897	54.1592
2025	11	26	21	38	1	23.67	96.8	6.897	54.1592
2025	11	26	21	48	1	24.63	95.8	6.897	56.4639
2025	11	26	21	58	1	23.31	97.6	6.897	53.2374
2025	11	26	22	8	1	23.74	96.3	6.897	54.3897
2025	11	26	22	18	1	25.67	98.3	6.897	58.5381
2025	11	26	22	28	1	23.62	97.8	6.897	53.9289
2025	11	26	22	38	1	23.69	97.3	6.897	54.1593
2025	11	26	22	48	1	24.56	96.5	6.897	56.2336
2025	11	26	22	58	1	24.27	98.5	6.897	55.3117
2025	11	26	23	8	1	25.01	99	6.897	56.925
2025	11	26	23	18	1	23.92	97.7	6.897	54.6204
2025	11	26	23	28	1	26.15	96.1	6.897	59.9211
2025	11	26	23	38	1	23.8	95.3	6.897	54.6204
2025	11	26	23	48	1	24.22	95.7	6.897	55.5423
2025	11	26	23	58	1	23.49	95.1	6.897	53.929

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	27	0	8	1	23.04	96.2	6.897	52.7767
2025	11	27	0	18	1	23.25	99.9	6.897	52.7767
2025	11	27	0	28	1	23.96	96.7	6.897	54.851
2025	11	27	0	38	1	23.4	100.6	6.897	53.0072
2025	11	27	0	48	1	24.96	98.3	6.897	56.9252
2025	11	27	0	58	1	24.01	97.7	6.897	54.851
2025	11	27	1	8	1	23.37	96.9	6.897	53.4682
2025	11	27	1	18	1	25.19	97.1	6.897	57.6166
2025	11	27	1	28	1	24.57	96.8	6.897	56.2338
2025	11	27	1	38	1	25.01	97.4	6.897	57.1557
2025	11	27	1	48	1	23.85	96.5	6.897	54.6206
2025	11	27	1	58	1	24.48	97	6.897	56.0034
2025	11	27	2	8	1	23.55	98.3	6.897	53.6987
2025	11	27	2	18	1	25.09	98.7	6.897	57.1557
2025	11	27	2	28	1	24.89	100.2	6.897	56.4643
2025	11	27	2	38	1	24.6	97.2	6.897	56.2339
2025	11	27	2	48	1	24.68	100	6.897	56.0034
2025	11	27	2	58	1	24.71	97.4	6.897	56.4643
2025	11	27	3	8	1	24.75	98.1	6.897	56.4643
2025	11	27	3	18	1	24.41	97.5	6.897	55.7729
2025	11	27	3	28	1	24.91	97.4	6.897	56.9253
2025	11	27	3	38	1	24.76	96.5	6.897	56.6948
2025	11	27	3	48	1	24.35	98.3	6.897	55.5425
2025	11	27	3	58	1	24.73	97.9	6.897	56.4644
2025	11	27	4	8	1	24.96	98.3	6.897	56.9253
2025	11	27	4	18	1	25.1	97.3	6.897	57.3862
2025	11	27	4	28	1	23.8	97.5	6.897	54.3902
2025	11	27	4	38	1	23.32	95.9	6.897	53.4683
2025	11	27	4	48	1	24.73	97.9	6.897	56.4644
2025	11	27	4	58	1	25.11	95.5	6.897	57.6167
2025	11	27	5	8	1	24.03	97.9	6.897	54.8511
2025	11	27	5	18	1	25.26	96.4	6.9031	57.9007
2025	11	27	5	28	1	24.73	95.8	6.897	56.6948
2025	11	27	5	38	1	24.34	96.1	6.9031	55.8246
2025	11	27	5	48	1	23.51	99.3	6.9031	53.5178
2025	11	27	5	58	1	24.82	97.6	6.9031	56.7473
2025	11	27	6	8	1	24.71	97.4	6.9031	56.5166
2025	11	27	6	18	1	23.79	98.9	6.9031	54.2098
2025	11	27	6	28	1	24.37	98.5	6.897	55.5425
2025	11	27	6	38	1	24.82	99.3	6.9031	56.5166
2025	11	27	6	48	1	25.3	98.9	6.9031	57.67
2025	11	27	6	58	1	24.41	97.5	6.9031	55.8246
2025	11	27	7	8	1	23.78	97	6.9031	54.4405
2025	11	27	7	18	1	25.26	98.2	6.9031	57.67
2025	11	27	7	28	1	25.1	97.3	6.9031	57.4393
2025	11	27	7	38	1	24.32	97.8	6.9031	55.5939
2025	11	27	7	48	1	24	99.1	6.9031	54.6712
2025	11	27	7	58	1	23.92	95.8	6.9092	54.9526

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	27	8	8	1	23.67	96.8	6.9092	54.2599
2025	11	27	8	18	1	23.86	96.7	6.9092	54.7217
2025	11	27	8	28	1	26.14	97.7	6.9092	59.8013
2025	11	27	8	38	1	24.44	98	6.9031	55.8245
2025	11	27	8	48	1	24.85	98.1	6.9092	56.7997
2025	11	27	8	58	1	25.09	97.1	6.9092	57.4924
2025	11	27	9	8	1	23.99	97.2	6.9092	54.9525
2025	11	27	9	18	1	23.84	98.2	6.9092	54.4907
2025	11	27	9	28	1	24.04	98.1	6.9092	54.9525
2025	11	27	9	38	1	23.77	96.8	6.9092	54.4907
2025	11	27	9	48	1	24	99.1	6.9092	54.7215
2025	11	27	9	58	1	24.85	98.1	6.9153	56.852
2025	11	27	10	8	1	24.45	98.2	6.9153	55.9276
2025	11	27	10	18	1	24.56	96.5	6.9153	56.3897
2025	11	27	10	28	1	24.66	96.5	6.9153	56.6208
2025	11	27	10	38	1	24.89	97.2	6.9153	57.083
2025	11	27	10	48	1	23.32	97.9	6.9153	53.3853
2025	11	27	10	58	1	24.43	99.4	6.9153	55.6963
2025	11	27	11	8	1	24.22	100.7	6.9153	55.003
2025	11	27	11	18	1	23.99	98.9	6.9153	54.7719
2025	11	27	11	28	1	23.92	99.4	6.9153	54.5407
2025	11	27	11	38	1	23.2	99.2	6.9153	52.923
2025	11	27	11	48	1	24.79	98.8	6.9214	56.6729
2025	11	27	11	58	1	24.6	100.3	6.9214	55.9789
2025	11	27	12	8	1	23.36	101.4	6.9214	52.9717
2025	11	27	12	18	1	24.04	98.1	6.9214	55.0536
2025	11	27	12	28	1	23.97	100.1	6.9214	54.5909
2025	11	27	12	38	1	23.05	100	6.9275	52.5574
2025	11	27	12	48	1	24.23	99.5	6.9275	55.3358
2025	11	27	12	58	1	24.91	99	6.9214	56.904
2025	11	27	13	8	1	24.82	99.3	6.9275	56.7249
2025	11	27	13	18	1	24.68	98.6	6.9275	56.4934
2025	11	27	13	28	1	24.61	97.5	6.9275	56.4934
2025	11	27	13	38	1	23.54	99.8	6.9275	53.715
2025	11	27	13	48	1	24.77	101.2	6.9275	56.2618
2025	11	27	13	58	1	25.38	96.8	6.9275	58.3456
2025	11	27	14	8	1	23.77	98.7	6.9275	54.4095
2025	11	27	14	18	1	24.47	98.5	6.9275	56.0303
2025	11	27	14	28	1	24.25	98.3	6.9336	55.6184
2025	11	27	14	38	1	23.56	100	6.9275	53.715
2025	11	27	14	48	1	23.18	100.4	6.9336	52.8375
2025	11	27	14	58	1	24.13	97.9	6.9275	55.3357
2025	11	27	15	8	1	25.06	98.3	6.9336	57.4723
2025	11	27	15	18	1	23.83	96	6.9336	54.9231
2025	11	27	15	28	1	24.2	97.4	6.9336	55.6183
2025	11	27	15	38	1	23.74	96.3	6.9336	54.6914
2025	11	27	15	48	1	23.51	99.3	6.9397	53.8139
2025	11	27	15	58	1	24.6	97.2	6.9397	56.5974

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	27	16	8	1	24.26	96.6	6.9458	55.9529
2025	11	27	16	18	1	22.84	96.3	6.9458	52.7025
2025	11	27	16	28	1	23.36	98.6	6.9519	53.6805
2025	11	27	16	38	1	24.76	98.4	6.9519	56.9338
2025	11	27	16	48	1	25.59	97	6.9519	59.0253
2025	11	27	16	58	1	24.3	99	6.958	55.8231
2025	11	27	17	8	1	25.23	95.9	6.958	58.3817
2025	11	27	17	18	1	24.65	96.3	6.958	56.9861
2025	11	27	17	28	1	25.42	97.5	6.958	58.6143
2025	11	27	17	38	1	25.07	98.5	6.958	57.6839
2025	11	27	17	48	1	23.51	99.3	6.958	53.9624
2025	11	27	17	58	1	24.5	97.3	6.958	56.521
2025	11	27	18	8	1	24.6	98.9	6.958	56.521
2025	11	27	18	18	1	24.88	96.9	6.958	57.4514
2025	11	27	18	28	1	25.13	97.8	6.958	57.9166
2025	11	27	18	38	1	24.52	97.7	6.958	56.521
2025	11	27	18	48	1	26.18	98.3	6.958	60.2426
2025	11	27	18	58	1	24.95	98.1	6.958	57.4515
2025	11	27	19	8	1	24.96	94.1	6.958	57.9167
2025	11	27	19	18	1	25.47	99.7	6.958	58.3819
2025	11	27	19	28	1	24.6	98.9	6.958	56.5211
2025	11	27	19	38	1	24.76	98.4	6.958	56.9864
2025	11	27	19	48	1	24	97.4	6.958	55.3582
2025	11	27	19	58	1	24.95	98.1	6.958	57.4516
2025	11	27	20	8	1	25.43	99.3	6.958	58.382
2025	11	27	20	18	1	25.02	97.6	6.958	57.6843
2025	11	27	20	28	1	25.26	98.2	6.958	58.1495
2025	11	27	20	38	1	24.79	98.8	6.958	56.9865
2025	11	27	20	48	1	25.2	97.3	6.958	58.1495
2025	11	27	20	58	1	25.45	96.3	6.958	58.8473
2025	11	27	21	8	1	25.71	98.9	6.958	59.0799
2025	11	27	21	18	1	24.09	98.8	6.958	55.3584
2025	11	27	21	28	1	24.45	98.2	6.958	56.2888
2025	11	27	21	38	1	24.84	96	6.958	57.4518
2025	11	27	21	48	1	25.26	98.2	6.958	58.1497
2025	11	27	21	58	1	24.54	96.1	6.958	56.7541
2025	11	27	22	8	1	24.6	97.2	6.958	56.7541
2025	11	27	22	18	1	25.27	98.4	6.958	58.1497
2025	11	27	22	28	1	25.54	97.9	6.958	58.8475
2025	11	27	22	38	1	24.71	97.4	6.958	56.9868
2025	11	27	22	48	1	25.13	97.8	6.958	57.9172
2025	11	27	22	58	1	24.37	98.5	6.9641	56.1078
2025	11	27	23	8	1	25.01	97.4	6.958	57.6846
2025	11	27	23	18	1	25.81	98.9	6.958	59.3128
2025	11	27	23	28	1	26.05	97.9	6.958	60.0107
2025	11	27	23	38	1	26.38	98.3	6.958	60.7085
2025	11	27	23	48	1	26.13	95.7	6.958	60.4759
2025	11	27	23	58	1	25.23	97.7	6.958	58.1499

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	28	0	8	1	24.55	98.2	6.958	56.5217
2025	11	28	0	18	1	25.14	98	6.958	57.9174
2025	11	28	0	28	1	25.16	98.2	6.958	57.9174
2025	11	28	0	38	1	25.05	98	6.958	57.6848
2025	11	28	0	48	1	26.43	97.6	6.958	60.9412
2025	11	28	0	58	1	25.78	99.8	6.958	59.0804
2025	11	28	1	8	1	23.93	97.9	6.958	55.1262
2025	11	28	1	18	1	23.54	96.3	6.958	54.4284
2025	11	28	1	28	1	25.6	97.2	6.958	59.0804
2025	11	28	1	38	1	24.94	99.5	6.958	57.2197
2025	11	28	1	48	1	25.01	99	6.958	57.4523
2025	11	28	1	58	1	24.43	99.4	6.958	56.0567
2025	11	28	2	8	1	25.05	98	6.958	57.6849
2025	11	28	2	18	1	25.06	96.4	6.958	57.9175
2025	11	28	2	28	1	24.67	94.4	6.958	57.2197
2025	11	28	2	38	1	24.78	97	6.958	57.2197
2025	11	28	2	48	1	24.75	98.1	6.958	56.9871
2025	11	28	2	58	1	26.49	98.5	6.958	60.9413
2025	11	28	3	8	1	24.94	99.5	6.9641	57.2722
2025	11	28	3	18	1	25.88	98.4	6.958	59.5457
2025	11	28	3	28	1	24.79	94.9	6.9641	57.505
2025	11	28	3	38	1	24.25	96.4	6.9641	56.1081
2025	11	28	3	48	1	25.1	97.3	6.9641	57.9706
2025	11	28	3	58	1	25.7	100.1	6.9641	58.9019
2025	11	28	4	8	1	24.64	97.9	6.958	56.7545
2025	11	28	4	18	1	25.8	98.7	6.9641	59.3675
2025	11	28	4	28	1	25.5	97.2	6.9641	58.9019
2025	11	28	4	38	1	25.3	98.9	6.9641	58.2034
2025	11	28	4	48	1	24.73	97.9	6.9641	57.0394
2025	11	28	4	58	1	25.65	96.3	6.9641	59.3675
2025	11	28	5	8	1	24.12	95.7	6.9641	55.8753
2025	11	28	5	18	1	25.46	98.1	6.9641	58.6691
2025	11	28	5	28	1	25.67	101	6.9641	58.6691
2025	11	28	5	38	1	26.79	96.9	6.9641	61.9284
2025	11	28	5	48	1	26.04	97.7	6.9641	60.0659
2025	11	28	5	58	1	24.97	101.1	6.9641	57.0393
2025	11	28	6	8	1	25.68	98.5	6.9641	59.1347
2025	11	28	6	18	1	24.57	98.4	6.9641	56.5737
2025	11	28	6	28	1	23.71	95.6	6.9641	54.944
2025	11	28	6	38	1	25.44	97.9	6.9641	58.669
2025	11	28	6	48	1	25.55	100.8	6.9641	58.4362
2025	11	28	6	58	1	24.68	98.6	6.9641	56.8065
2025	11	28	7	8	1	24.84	96	6.9641	57.505
2025	11	28	7	18	1	24.89	97.2	6.9641	57.505
2025	11	28	7	28	1	25.74	97.8	6.9641	59.3675
2025	11	28	7	38	1	25.21	95.2	6.9641	58.4362
2025	11	28	7	48	1	25.39	97	6.9641	58.669
2025	11	28	7	58	1	25.95	96.2	6.9641	60.0659

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	28	8	8	1	25.24	96.1	6.9702	58.4898
2025	11	28	8	18	1	24.02	99.3	6.9641	55.1768
2025	11	28	8	28	1	23.79	97.2	6.9641	54.944
2025	11	28	8	38	1	25.46	98.1	6.9641	58.669
2025	11	28	8	48	1	24.5	100.3	6.9702	56.1595
2025	11	28	8	58	1	25.23	97.7	6.9641	58.2034
2025	11	28	9	8	1	25.3	95.2	6.9702	58.7228
2025	11	28	9	18	1	24.12	95.7	6.9702	55.9264
2025	11	28	9	28	1	23.76	98.5	6.9702	54.7613
2025	11	28	9	38	1	24.78	97	6.9702	57.3245
2025	11	28	9	48	1	23.97	98.6	6.9702	55.2273
2025	11	28	9	58	1	25.07	96.6	6.9702	58.0236
2025	11	28	10	8	1	24.71	97.4	6.9702	57.0914
2025	11	28	10	18	1	25.9	97.1	6.9702	59.8877
2025	11	28	10	28	1	26.22	97.5	6.9702	60.5867
2025	11	28	10	38	1	23.92	97.7	6.9702	55.2271
2025	11	28	10	48	1	25.19	97.1	6.9702	58.2564
2025	11	28	10	58	1	25.13	97.8	6.9702	58.0234
2025	11	28	11	8	1	25.2	95	6.9702	58.4894
2025	11	28	11	18	1	25.16	96.4	6.9702	58.2563
2025	11	28	11	28	1	25.84	97.8	6.9702	59.6545
2025	11	28	11	38	1	24.91	97.4	6.9702	57.5572
2025	11	28	11	48	1	24.75	96.3	6.9702	57.3242
2025	11	28	11	58	1	26.04	97.7	6.9702	60.1204
2025	11	28	12	8	1	24.68	98.6	6.9763	56.9101
2025	11	28	12	18	1	23.89	97.2	6.9763	55.2774
2025	11	28	12	28	1	25.43	97.7	6.9763	58.776
2025	11	28	12	38	1	25.74	96	6.9763	59.7089
2025	11	28	12	48	1	25.21	95.2	6.9763	58.5427
2025	11	28	12	58	1	24.76	96.5	6.9702	57.324
2025	11	28	13	8	1	24.86	96.5	6.9702	57.557
2025	11	28	13	18	1	24.75	98.1	6.9763	57.1432
2025	11	28	13	28	1	25.44	96.1	6.9702	58.9551
2025	11	28	13	38	1	24.46	96.6	6.9763	56.6767
2025	11	28	13	48	1	25.39	97	6.9763	58.7758
2025	11	28	13	58	1	24.25	98.3	6.9763	55.9769
2025	11	28	14	8	1	25.2	97.3	6.9763	58.3093
2025	11	28	14	18	1	25.18	96.8	6.9763	58.3093
2025	11	28	14	28	1	24.11	97.6	6.9763	55.7437
2025	11	28	14	38	1	24.72	97.7	6.9763	57.1431
2025	11	28	14	48	1	24.43	95.9	6.9763	56.6766
2025	11	28	14	58	1	25.5	98.8	6.9763	58.7757
2025	11	28	15	8	1	24.76	98.4	6.9763	57.1431
2025	11	28	15	18	1	26.08	98.4	6.9824	60.2302
2025	11	28	15	28	1	24.6	97.2	6.9763	56.9098
2025	11	28	15	38	1	26.08	98.4	6.9824	60.2302
2025	11	28	15	48	1	24.61	97.5	6.9824	56.9619
2025	11	28	15	58	1	24.57	98.4	6.9763	56.6766

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	28	16	8	1	25.29	97	6.9763	58.5425
2025	11	28	16	18	1	25.69	96.9	6.9763	59.4755
2025	11	28	16	28	1	24.51	97.5	6.9763	56.6766
2025	11	28	16	38	1	24.41	97.5	6.9763	56.4434
2025	11	28	16	48	1	25.18	96.8	6.9763	58.3093
2025	11	28	16	58	1	24.34	98	6.9763	56.2102
2025	11	28	17	8	1	24.15	98.3	6.9824	55.7947
2025	11	28	17	18	1	25.13	97.8	6.9824	58.1292
2025	11	28	17	28	1	25.8	100	6.9763	59.2423
2025	11	28	17	38	1	25.09	98.7	6.9763	57.8429
2025	11	28	17	48	1	24.96	98.3	6.9763	57.6096
2025	11	28	17	58	1	25.37	98.4	6.9763	58.5426
2025	11	28	18	8	1	25.32	97.5	6.9763	58.5426
2025	11	28	18	18	1	24.52	95.6	6.9763	56.9099
2025	11	28	18	28	1	26.15	96.1	6.9763	60.6417
2025	11	28	18	38	1	24.26	96.6	6.9824	56.2617
2025	11	28	18	48	1	24.17	98.6	6.9824	55.7948
2025	11	28	18	58	1	24.06	96.7	6.9763	55.7438
2025	11	28	19	8	1	26.42	97.4	6.9763	61.1083
2025	11	28	19	18	1	25.5	97.2	6.9763	59.0092
2025	11	28	19	28	1	25.8	98.7	6.9763	59.4757
2025	11	28	19	38	1	25.01	97.4	6.9763	57.843
2025	11	28	19	48	1	25.55	96.3	6.9763	59.2425
2025	11	28	19	58	1	25.11	95.5	6.9763	58.3096
2025	11	28	20	8	1	26.56	98	6.9763	61.3417
2025	11	28	20	18	1	24.87	96.7	6.9763	57.6099
2025	11	28	20	28	1	24.72	95.6	6.9763	57.3767
2025	11	28	20	38	1	24.86	98.3	6.9763	57.3767
2025	11	28	20	48	1	25.84	97.8	6.9763	59.7091
2025	11	28	20	58	1	25.28	96.8	6.9763	58.5429
2025	11	28	21	8	1	24.65	96.3	6.9763	57.1435
2025	11	28	21	18	1	25.23	97.7	6.9763	58.3097
2025	11	28	21	28	1	25.61	99	6.9763	59.0095
2025	11	28	21	38	1	24.51	99.2	6.9763	56.4439
2025	11	28	21	48	1	25.01	97.4	6.9763	57.8433
2025	11	28	21	58	1	25.39	98.6	6.9763	58.543
2025	11	28	22	8	1	24.64	99.6	6.9763	56.6772
2025	11	28	22	18	1	25.89	96.9	6.9702	59.8877
2025	11	28	22	28	1	24.44	98	6.9702	56.3924
2025	11	28	22	38	1	25.98	98.4	6.9702	59.8878
2025	11	28	22	48	1	25.16	98.2	6.9702	58.0236
2025	11	28	22	58	1	24.78	97	6.9702	57.3245
2025	11	28	23	8	1	25.4	95	6.9702	58.9557
2025	11	28	23	18	1	24.68	94.6	6.9702	57.3246
2025	11	28	23	28	1	25.3	97.3	6.9702	58.4897
2025	11	28	23	38	1	25.53	97.7	6.9702	58.9558
2025	11	28	23	48	1	24.41	97.5	6.9702	56.3925
2025	11	28	23	58	1	24.87	96.7	6.9702	57.5577

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	29	0	8	1	27.05	97.9	6.9702	62.4513
2025	11	29	0	18	1	25.07	98.5	6.9702	57.7907
2025	11	29	0	28	1	25.74	97.8	6.9702	59.4219
2025	11	29	0	38	1	25.24	99.4	6.9702	58.0238
2025	11	29	0	48	1	24.45	99.7	6.9702	56.1596
2025	11	29	0	58	1	25.36	98.2	6.9702	58.4899
2025	11	29	1	8	1	24.55	98.2	6.9702	56.6257
2025	11	29	1	18	1	25.7	97.2	6.9702	59.422
2025	11	29	1	28	1	24.68	98.6	6.9702	56.8587
2025	11	29	1	38	1	24.82	97.6	6.9702	57.3248
2025	11	29	1	48	1	25.38	96.8	6.9702	58.7229
2025	11	29	1	58	1	25.81	97.3	6.9702	59.6551
2025	11	29	2	8	1	25.46	98.1	6.9702	58.7229
2025	11	29	2	18	1	25.9	98.7	6.9702	59.6551
2025	11	29	2	28	1	25.14	99.4	6.9702	57.7908
2025	11	29	2	38	1	24.76	99.8	6.9702	56.8587
2025	11	29	2	48	1	24.76	96.5	6.9702	57.3248
2025	11	29	2	58	1	25.91	97.3	6.9702	59.8881
2025	11	29	3	8	1	25.42	97.5	6.9702	58.7229
2025	11	29	3	18	1	24.62	97.7	6.9702	56.8587
2025	11	29	3	28	1	24.87	96.7	6.9641	57.5051
2025	11	29	3	38	1	25.12	97.5	6.9702	58.0239
2025	11	29	3	48	1	25.66	99.6	6.9702	58.956
2025	11	29	3	58	1	24.27	100	6.9702	55.6936
2025	11	29	4	8	1	24.33	99.5	6.9702	55.9266
2025	11	29	4	18	1	25.5	97.2	6.9641	58.902
2025	11	29	4	28	1	24.27	100	6.9702	55.6936
2025	11	29	4	38	1	25.47	99.7	6.9702	58.4899
2025	11	29	4	48	1	24.74	99.5	6.9641	56.8067
2025	11	29	4	58	1	25.43	99.3	6.9702	58.4899
2025	11	29	5	8	1	24.02	95.7	6.9702	55.6936
2025	11	29	5	18	1	25.02	99.2	6.9702	57.5578
2025	11	29	5	28	1	24.65	98.2	6.9641	56.8067
2025	11	29	5	38	1	25.48	98.6	6.9641	58.6692
2025	11	29	5	48	1	24.28	98.8	6.9702	55.9266
2025	11	29	5	58	1	25.7	97.2	6.9641	59.3676
2025	11	29	6	8	1	24.73	97.9	6.9641	57.0395
2025	11	29	6	18	1	25.47	98.4	6.9702	58.7229
2025	11	29	6	28	1	25.87	98.2	6.9641	59.6004
2025	11	29	6	38	1	24.01	97.7	6.9702	55.4606
2025	11	29	6	48	1	25.39	98.6	6.9702	58.4899
2025	11	29	6	58	1	24.25	96.4	6.9641	56.1082
2025	11	29	7	8	1	24.11	97.6	6.9702	55.6936
2025	11	29	7	18	1	24.82	97.6	6.9702	57.3248
2025	11	29	7	28	1	23.82	97.7	6.9702	54.9945
2025	11	29	7	38	1	23.99	97.2	6.9702	55.4605
2025	11	29	7	48	1	24.21	97.6	6.9702	55.9266
2025	11	29	7	58	1	25.44	97.9	6.9702	58.7229

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	29	8	8	1	24.16	96.7	6.9702	55.9266
2025	11	29	8	18	1	25.38	96.8	6.9702	58.7229
2025	11	29	8	28	1	24.79	94.9	6.9641	57.5051
2025	11	29	8	38	1	24.62	97.7	6.9702	56.8587
2025	11	29	8	48	1	24.2	100.5	6.9641	55.4097
2025	11	29	8	58	1	25.05	99.7	6.9641	57.505
2025	11	29	9	8	1	25.56	99.7	6.9702	58.7229
2025	11	29	9	18	1	25.07	98.5	6.9702	57.7907
2025	11	29	9	28	1	25.5	98.8	6.9702	58.7228
2025	11	29	9	38	1	24.95	98.1	6.9702	57.5577
2025	11	29	9	48	1	23.18	98.9	6.9641	53.3143
2025	11	29	9	58	1	24.02	99.3	6.9641	55.1768
2025	11	29	10	8	1	24.73	99.3	6.9702	56.8585
2025	11	29	10	18	1	24.82	97.6	6.9641	57.272
2025	11	29	10	28	1	25.58	96.7	6.9702	59.1887
2025	11	29	10	38	1	23.76	98.5	6.9641	54.7111
2025	11	29	10	48	1	24.35	98.3	6.9702	56.1593
2025	11	29	10	58	1	23.84	99.7	6.9702	54.7611
2025	11	29	11	8	1	23.58	98.8	6.9702	54.2951
2025	11	29	11	18	1	24.96	96.4	6.9702	57.7905
2025	11	29	11	28	1	24.27	98.5	6.9702	55.9262
2025	11	29	11	38	1	24.91	97.4	6.9702	57.5574
2025	11	29	11	48	1	24.48	97	6.9702	56.6253
2025	11	29	11	58	1	24.45	99.7	6.9702	56.1592
2025	11	29	12	8	1	23.47	96.9	6.9702	54.295
2025	11	29	12	18	1	25.3	97.3	6.9702	58.4894
2025	11	29	12	28	1	23.69	97.3	6.9702	54.761
2025	11	29	12	38	1	24.38	98.7	6.9702	56.1591
2025	11	29	12	48	1	24.38	98.7	6.9702	56.1591
2025	11	29	12	58	1	24.89	98.8	6.9702	57.3242
2025	11	29	13	8	1	25.54	97.9	6.9702	58.9554
2025	11	29	13	18	1	24.43	95.9	6.9702	56.6251
2025	11	29	13	28	1	24.95	96.2	6.9702	57.7902
2025	11	29	13	38	1	24.33	95.9	6.9702	56.392
2025	11	29	13	48	1	24.05	96.4	6.9702	55.6929
2025	11	29	13	58	1	23.92	95.8	6.9702	55.4599
2025	11	29	14	8	1	23.54	96.3	6.9763	54.5777
2025	11	29	14	18	1	23.01	97.7	6.9763	53.1783
2025	11	29	14	28	1	24.13	95.9	6.9763	55.9771
2025	11	29	14	38	1	24.38	94.7	6.9763	56.6768
2025	11	29	14	48	1	24.42	97.8	6.9702	56.392
2025	11	29	14	58	1	23.47	96.9	6.9763	54.3445
2025	11	29	15	8	1	24.68	94.6	6.9763	57.3766
2025	11	29	15	18	1	23.94	96.2	6.9763	55.5107
2025	11	29	15	28	1	23.89	95	6.9763	55.5106
2025	11	29	15	38	1	24.65	96.3	6.9763	57.1433
2025	11	29	15	48	1	24.19	95	6.9763	56.2104
2025	11	29	15	58	1	25.06	96.4	6.9763	58.0763

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	29	16	8	1	24.48	100.1	6.9763	56.2104
2025	11	29	16	18	1	25.85	96.2	6.9763	59.9422
2025	11	29	16	28	1	23.69	99	6.9763	54.5777
2025	11	29	16	38	1	24.78	97	6.9763	57.3766
2025	11	29	16	48	1	25.06	96.4	6.9763	58.0763
2025	11	29	16	58	1	25.39	97	6.9763	58.776
2025	11	29	17	8	1	24.71	97.4	6.9763	57.1434
2025	11	29	17	18	1	24.32	95.7	6.9763	56.4436
2025	11	29	17	28	1	23.16	94	6.9763	53.878
2025	11	29	17	38	1	25.44	93.4	6.9763	59.2425
2025	11	29	17	48	1	22.81	95.5	6.9763	52.9451
2025	11	29	17	58	1	24.15	93.8	6.9763	56.2105
2025	11	29	18	8	1	24.41	97.5	6.9763	56.4437
2025	11	29	18	18	1	24.49	94.9	6.9763	56.9102
2025	11	29	18	28	1	24.65	96.3	6.9763	57.1435
2025	11	29	18	38	1	24.51	95.4	6.9763	56.9102
2025	11	29	18	48	1	24.22	95.7	6.9702	56.1591
2025	11	29	18	58	1	24.57	96.8	6.9702	56.8582
2025	11	29	19	8	1	24.98	94.6	6.9763	58.0765
2025	11	29	19	18	1	24.49	94.9	6.9702	56.8583
2025	11	29	19	28	1	23.95	96.5	6.9763	55.5109
2025	11	29	19	38	1	23.94	93.1	6.9763	55.7442
2025	11	29	19	48	1	22.98	97.2	6.9702	53.1299
2025	11	29	19	58	1	26.07	96.6	6.9702	60.3538
2025	11	29	20	8	1	24.66	96.5	6.9702	57.0914
2025	11	29	20	18	1	24.85	98.1	6.9702	57.3245
2025	11	29	20	28	1	25.08	96.9	6.9702	58.0236
2025	11	29	20	38	1	24.43	95.9	6.9702	56.6254
2025	11	29	20	48	1	24.15	96.4	6.9702	55.9264
2025	11	29	20	58	1	24.19	97.1	6.9702	55.9264
2025	11	29	21	8	1	25.16	96.4	6.9702	58.2567
2025	11	29	21	18	1	25.06	96.4	6.9702	58.0237
2025	11	29	21	28	1	25.41	95.4	6.9702	58.9558
2025	11	29	21	38	1	24.81	99	6.9702	57.0916
2025	11	29	21	48	1	24.12	100.8	6.9702	55.2274
2025	11	29	21	58	1	25.78	96.7	6.9702	59.655
2025	11	29	22	8	1	24.66	96.5	6.9702	57.0917
2025	11	29	22	18	1	23.84	98.2	6.9702	54.9945
2025	11	29	22	28	1	25.4	98.8	6.9702	58.4899
2025	11	29	22	38	1	24.68	98.6	6.9702	56.8587
2025	11	29	22	48	1	24.98	98.5	6.9702	57.5578
2025	11	29	22	58	1	23.69	97.3	6.9702	54.7615
2025	11	29	23	8	1	24.55	98.2	6.9702	56.6258
2025	11	29	23	18	1	25.75	96.2	6.9702	59.6552
2025	11	29	23	28	1	24.24	98.1	6.9702	55.9267
2025	11	29	23	38	1	24.37	98.5	6.9702	56.1598
2025	11	29	23	48	1	25.32	95.7	6.9702	58.7231
2025	11	29	23	58	1	24.31	95.4	6.9702	56.3928

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	30	0	8	1	24.64	96.1	6.9641	57.0397
2025	11	30	0	18	1	23.62	95.8	6.9702	54.7617
2025	11	30	0	28	1	23.6	95.3	6.9702	54.7617
2025	11	30	0	38	1	23.68	94.8	6.9702	54.9947
2025	11	30	0	48	1	24.37	96.8	6.9641	56.3413
2025	11	30	0	58	1	24.12	95.7	6.9702	55.9269
2025	11	30	1	8	1	24.45	96.3	6.9641	56.5741
2025	11	30	1	18	1	24.03	96	6.9641	55.6429
2025	11	30	1	28	1	24.22	95.7	6.9641	56.1085
2025	11	30	1	38	1	25.21	95.5	6.9641	58.4367
2025	11	30	1	48	1	24.72	92.5	6.9641	57.5054
2025	11	30	1	58	1	24.29	97.1	6.9641	56.1085
2025	11	30	2	8	1	23.54	93.4	6.9641	54.7117
2025	11	30	2	18	1	23.72	95.8	6.9641	54.9445
2025	11	30	2	28	1	24.04	96.2	6.9641	55.6429
2025	11	30	2	38	1	24.42	95.6	6.9641	56.5742
2025	11	30	2	48	1	24	95.3	6.9641	55.6429
2025	11	30	2	58	1	24.14	98.1	6.9641	55.6429
2025	11	30	3	8	1	24.88	96.9	6.9641	57.5055
2025	11	30	3	18	1	24.25	98.3	6.9641	55.8758
2025	11	30	3	28	1	23.4	95.4	6.9641	54.2461
2025	11	30	3	38	1	22.91	95.5	6.9702	53.1306
2025	11	30	3	48	1	23.17	96.9	6.9641	53.5476
2025	11	30	3	58	1	24.35	98.3	6.9641	56.1086
2025	11	30	4	8	1	22.73	96.1	6.9641	52.6163
2025	11	30	4	18	1	24.99	97.1	6.9641	57.7383
2025	11	30	4	28	1	23.52	97.8	6.9702	54.2958
2025	11	30	4	38	1	23.77	96.8	6.9641	54.9445
2025	11	30	4	48	1	24.11	95.5	6.9702	55.927
2025	11	30	4	58	1	24.25	96.4	6.9641	56.1086
2025	11	30	5	8	1	23.12	96	6.9641	53.5476
2025	11	30	5	18	1	24.04	96.2	6.9702	55.6939
2025	11	30	5	28	1	22.79	95	6.9641	52.8492
2025	11	30	5	38	1	23.42	95.9	6.9702	54.2958
2025	11	30	5	48	1	25.05	96.2	6.9702	58.0242
2025	11	30	5	58	1	24.22	95.7	6.9702	56.16
2025	11	30	6	8	1	23.6	97.5	6.9702	54.5288
2025	11	30	6	18	1	24.42	97.8	6.9702	56.393
2025	11	30	6	28	1	23.86	96.7	6.9702	55.2279
2025	11	30	6	38	1	23.49	97.3	6.9702	54.2958
2025	11	30	6	48	1	23.19	97.4	6.9702	53.5967
2025	11	30	6	58	1	22.98	99	6.9702	52.8976
2025	11	30	7	8	1	23.26	98.7	6.9702	53.5967
2025	11	30	7	18	1	22.5	95.4	6.9702	52.1985
2025	11	30	7	28	1	22.61	95.6	6.9702	52.4315
2025	11	30	7	38	1	24.11	97.6	6.9702	55.6939
2025	11	30	7	48	1	23.92	97.7	6.9702	55.2279
2025	11	30	7	58	1	24.2	97.4	6.9702	55.9269

Reinhackle (0365)

Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	30	8	8	1	23.92	97.7	6.9702	55.2279
2025	11	30	8	18	1	24.06	96.7	6.9702	55.6939
2025	11	30	8	28	1	24.05	96.4	6.9702	55.6939
2025	11	30	8	38	1	24.32	95.7	6.9702	56.393
2025	11	30	8	48	1	23.09	95	6.9702	53.5966
2025	11	30	8	58	1	23.18	97.2	6.9702	53.5966
2025	11	30	9	8	1	22.01	97.8	6.9702	50.8003
2025	11	30	9	18	1	23.72	97.8	6.9702	54.7618
2025	11	30	9	28	1	23.2	95.4	6.9702	53.8296
2025	11	30	9	38	1	22.42	95.9	6.9702	51.9654
2025	11	30	9	48	1	23.49	95.1	6.9702	54.5287
2025	11	30	9	58	1	24.05	93.8	6.9702	55.9268
2025	11	30	10	8	1	23.49	94.9	6.9702	54.5287
2025	11	30	10	18	1	22.92	98	6.9702	52.8974
2025	11	30	10	28	1	23.25	99.9	6.9702	53.3635
2025	11	30	10	38	1	24.64	99.6	6.9702	56.6258
2025	11	30	10	48	1	24.01	97.7	6.9702	55.4607
2025	11	30	10	58	1	24.02	99.3	6.9702	55.2276
2025	11	30	11	8	1	23.72	97.8	6.9702	54.7615
2025	11	30	11	18	1	23.39	99.1	6.9702	53.8294
2025	11	30	11	28	1	23.62	97.8	6.9702	54.5285
2025	11	30	11	38	1	25.03	95.7	6.9702	58.0239
2025	11	30	11	48	1	24.25	98.3	6.9702	55.9266
2025	11	30	11	58	1	23.58	97.1	6.9702	54.5284
2025	11	30	12	8	1	22.89	95	6.9702	53.1303
2025	11	30	12	18	1	24.14	96.2	6.9702	55.9266
2025	11	30	12	28	1	24.93	97.8	6.9702	57.5578
2025	11	30	12	38	1	24.36	96.6	6.9702	56.3926
2025	11	30	12	48	1	24.3	97.3	6.9702	56.1596
2025	11	30	12	58	1	24.3	97.3	6.9702	56.1595
2025	11	30	13	8	1	23.43	98.1	6.9702	54.0623
2025	11	30	13	18	1	24.23	97.8	6.9702	55.9265
2025	11	30	13	28	1	23.65	98.3	6.9702	54.5283
2025	11	30	13	38	1	25.4	97.2	6.9702	58.7228
2025	11	30	13	48	1	23.66	94.1	6.9702	54.9944
2025	11	30	13	58	1	25.53	97.7	6.9702	58.9558
2025	11	30	14	8	1	24.18	98.8	6.9702	55.6934
2025	11	30	14	18	1	24.57	96.8	6.9702	56.8585
2025	11	30	14	28	1	22.92	98	6.9702	52.897
2025	11	30	14	38	1	24.17	94.3	6.9702	56.1594
2025	11	30	14	48	1	23.81	95.5	6.9702	55.2273
2025	11	30	14	58	1	24.98	96.9	6.9702	57.7906
2025	11	30	15	8	1	23.09	95	6.9702	53.5961
2025	11	30	15	18	1	23.67	96.8	6.9702	54.7613
2025	11	30	15	28	1	24.16	96.7	6.9702	55.9264
2025	11	30	15	38	1	24.35	99.7	6.9702	55.9264
2025	11	30	15	48	1	22.92	95.8	6.9702	53.1301
2025	11	30	15	58	1	23.92	97.7	6.9702	55.2273

Reinhackle (0365)									
Year	Month	Day	Hour	Minute	Second	Speed	Direction	Area	Flow
2025	11	30	16	8	1	24.12	100.8	6.9702	55.2273
2025	11	30	16	18	1	24.45	96.3	6.9702	56.6255
2025	11	30	16	28	1	24.58	97	6.9702	56.8585
2025	11	30	16	38	1	24.04	96.2	6.9702	55.6934
2025	11	30	16	48	1	23.52	95.9	6.9702	54.5283
2025	11	30	16	58	1	24.23	95.9	6.9702	56.1595
2025	11	30	17	8	1	24.18	94.7	6.9702	56.1595
2025	11	30	17	18	1	22.51	95.6	6.9702	52.198
2025	11	30	17	28	1	21.79	97.6	6.9702	50.3338
2025	11	30	17	38	1	22.97	97	6.9702	53.1302
2025	11	30	17	48	1	23.1	95.5	6.9702	53.5962
2025	11	30	17	58	1	23.28	97.2	6.9702	53.8292
2025	11	30	18	8	1	23.68	94.8	6.9702	54.9944
2025	11	30	18	18	1	23.36	94.2	6.9702	54.2953
2025	11	30	18	28	1	23.38	94.7	6.9702	54.2953
2025	11	30	18	38	1	23.03	93	6.9702	53.5963
2025	11	30	18	48	1	22.56	94.3	6.9702	52.4311
2025	11	30	18	58	1	24.14	96.2	6.9702	55.9266
2025	11	30	19	8	1	23.19	94.9	6.9641	53.7801
2025	11	30	19	18	1	22.09	97.5	6.9641	50.9863
2025	11	30	19	28	1	23.32	95.9	6.9641	54.0129
2025	11	30	19	38	1	23.58	97.1	6.9641	54.4786
2025	11	30	19	48	1	24.59	94.9	6.9641	57.0396
2025	11	30	19	58	1	24.29	95	6.9641	56.3411
2025	11	30	20	8	1	22.32	92.6	6.9641	51.9177
2025	11	30	20	18	1	23.32	97.9	6.9641	53.7802
2025	11	30	20	28	1	22.13	96.2	6.9641	51.2193
2025	11	30	20	38	1	24.1	95.2	6.9641	55.8756
2025	11	30	20	48	1	23.09	95	6.9641	53.5475
2025	11	30	20	58	1	23	95.2	6.9641	53.3147
2025	11	30	21	8	1	23.86	96.7	6.9641	55.1772
2025	11	30	21	18	1	23.16	94.2	6.9641	53.7803
2025	11	30	21	28	1	22.76	94	6.9641	52.8491
2025	11	30	21	38	1	23.88	94.6	6.9641	55.4101
2025	11	30	21	48	1	24.47	96.8	6.9641	56.5742
2025	11	30	21	58	1	24.11	97.6	6.9641	55.6429
2025	11	30	22	8	1	23.37	96.9	6.958	53.9638
2025	11	30	22	18	1	23.92	95.8	6.958	55.3594
2025	11	30	22	28	1	25.32	95.7	6.958	58.6158
2025	11	30	22	38	1	24.06	98.4	6.958	55.3594
2025	11	30	22	48	1	22.61	95.6	6.958	52.3356
2025	11	30	22	58	1	24.65	96.3	6.958	56.9877
2025	11	30	23	8	1	22.87	97	6.958	52.8009
2025	11	30	23	18	1	22.65	93.8	6.958	52.5683
2025	11	30	23	28	1	24.88	96.9	6.958	57.4529
2025	11	30	23	38	1	22.59	95.1	6.958	52.3357
2025	11	30	23	48	1	24.09	97.2	6.958	55.5921
2025	11	30	23	58	1	23.53	96.1	6.958	54.4292

Alabama Gates Release

Station 0087

Date	Flow (cfs)
11/1/2025	0.00
11/2/2025	0.00
11/3/2025	0.00
11/4/2025	0.00
11/5/2025	0.00
11/6/2025	0.00
11/7/2025	0.00
11/8/2025	0.00
11/9/2025	0.00
11/10/2025	0.00
11/11/2025	0.00
11/12/2025	0.00
11/13/2025	0.00
11/14/2025	0.00
11/15/2025	0.00
11/16/2025	0.00
11/17/2025	0.00
11/18/2025	0.00
11/19/2025	0.00
11/20/2025	0.00
11/21/2025	0.00
11/22/2025	0.00
11/23/2025	0.00
11/24/2025	0.00
11/25/2025	0.00
11/26/2025	0.00
11/27/2025	0.00
11/28/2025	0.00
11/29/2025	0.00
11/30/2025	0.00

Langemann Gate to Delta Weir to Delta Pumpback Station Discharge

DATE	FLOW (CFS)	FLOW (CFS)	FLOW (CFS)
11/1/2025	7	0	40
11/2/2025	7	0	40
11/3/2025	7	0	40
11/4/2025	7	0	42
11/5/2025	7	0	41
11/6/2025	7	0	42
11/7/2025	7	0	42
11/8/2025	7	0	42
11/9/2025	7	0	43
11/10/2025	7	0	44
11/11/2025	7	0	45
11/12/2025	7	0	47
11/13/2025	7	0	47
11/14/2025	7	0	47
11/15/2025	7	0	47
11/16/2025	7	7	47
11/17/2025	7	16	47
11/18/2025	7	31	47
11/19/2025	7	22	47
11/20/2025	7	21	47
11/21/2025	7	17	47
11/22/2025	7	12	47
11/23/2025	7	11	47
11/24/2025	7	8	47
11/25/2025	7	5	47
11/26/2025	7	3	47
11/27/2025	7	1	47
11/28/2025	7	0	47
11/29/2025	7	0	47
11/30/2025	7	0	46

Pumpback Station Discharge (0364)

11/1/25 0:00 == 37	11/1/25 4:30 == 47.9	11/1/25 9:00 == 32.4	11/1/25 13:30 == 47.9
11/1/25 0:05 == 32.6	11/1/25 4:35 == 47.9	11/1/25 9:05 == 32.5	11/1/25 13:35 == 48
11/1/25 0:10 == 32.6	11/1/25 4:40 == 48	11/1/25 9:10 == 33.1	11/1/25 13:40 == 47.2
11/1/25 0:15 == 32.8	11/1/25 4:45 == 37.3	11/1/25 9:15 == 37.7	11/1/25 13:45 == 40.8
11/1/25 0:20 == 32.7	11/1/25 4:50 == 33	11/1/25 9:20 == 47.4	11/1/25 13:50 == 32.5
11/1/25 0:25 == 32.6	11/1/25 4:55 == 32.6	11/1/25 9:25 == 47.9	11/1/25 13:55 == 32.7
11/1/25 0:30 == 32.6	11/1/25 5:00 == 32.6	11/1/25 9:30 == 47.9	11/1/25 14:00 == 32.7
11/1/25 0:35 == 32.7	11/1/25 5:05 == 32.6	11/1/25 9:35 == 47.9	11/1/25 14:05 == 32.6
11/1/25 0:40 == 33.4	11/1/25 5:10 == 32.6	11/1/25 9:40 == 47.6	11/1/25 14:10 == 32.6
11/1/25 0:45 == 39.6	11/1/25 5:15 == 32.4	11/1/25 9:45 == 47.8	11/1/25 14:15 == 32.5
11/1/25 0:50 == 47.3	11/1/25 5:20 == 32.5	11/1/25 9:50 == 47.9	11/1/25 14:20 == 32.5
11/1/25 0:55 == 47.8	11/1/25 5:25 == 32.5	11/1/25 9:55 == 47.6	11/1/25 14:25 == 33
11/1/25 1:00 == 47.9	11/1/25 5:30 == 40.1	11/1/25 10:00 == 47.8	11/1/25 14:30 == 36.7
11/1/25 1:05 == 48	11/1/25 5:35 == 46.9	11/1/25 10:05 == 48	11/1/25 14:35 == 48.1
11/1/25 1:10 == 47.9	11/1/25 5:40 == 47.9	11/1/25 10:10 == 47.9	11/1/25 14:40 == 48
11/1/25 1:15 == 47.9	11/1/25 5:45 == 47.8	11/1/25 10:15 == 38.5	11/1/25 14:45 == 47.9
11/1/25 1:20 == 47.9	11/1/25 5:50 == 47.5	11/1/25 10:20 == 33.3	11/1/25 14:50 == 47.8
11/1/25 1:25 == 46.1	11/1/25 5:55 == 47.5	11/1/25 10:25 == 32.4	11/1/25 14:55 == 48.1
11/1/25 1:30 == 38.2	11/1/25 6:00 == 47.5	11/1/25 10:30 == 32.4	11/1/25 15:00 == 47.9
11/1/25 1:35 == 32.5	11/1/25 6:05 == 47.6	11/1/25 10:35 == 32.5	11/1/25 15:05 == 47.9
11/1/25 1:40 == 32.6	11/1/25 6:10 == 46.2	11/1/25 10:40 == 32.5	11/1/25 15:10 == 47.5
11/1/25 1:45 == 32.5	11/1/25 6:15 == 39.9	11/1/25 10:45 == 32.6	11/1/25 15:15 == 48
11/1/25 1:50 == 32.5	11/1/25 6:20 == 32.4	11/1/25 10:50 == 32.7	11/1/25 15:20 == 48
11/1/25 1:55 == 32.4	11/1/25 6:25 == 32.4	11/1/25 10:55 == 32.7	11/1/25 15:25 == 48
11/1/25 2:00 == 32.6	11/1/25 6:30 == 32.5	11/1/25 11:00 == 38.5	11/1/25 15:30 == 39.4
11/1/25 2:05 == 32.6	11/1/25 6:35 == 32.5	11/1/25 11:05 == 46.6	11/1/25 15:35 == 33.8
11/1/25 2:10 == 32.6	11/1/25 6:40 == 32.5	11/1/25 11:10 == 47.6	11/1/25 15:40 == 32.7
11/1/25 2:15 == 40.7	11/1/25 6:45 == 32.5	11/1/25 11:15 == 47.7	11/1/25 15:45 == 32.8
11/1/25 2:20 == 46.7	11/1/25 6:50 == 32.5	11/1/25 11:20 == 47.8	11/1/25 15:50 == 33
11/1/25 2:25 == 47.3	11/1/25 6:55 == 32.5	11/1/25 11:25 == 47.5	11/1/25 15:55 == 33
11/1/25 2:30 == 47.8	11/1/25 7:00 == 32.6	11/1/25 11:30 == 47.8	11/1/25 16:00 == 33.1
11/1/25 2:35 == 48	11/1/25 7:05 == 32.6	11/1/25 11:35 == 48.1	11/1/25 16:05 == 33.1
11/1/25 2:40 == 48.1	11/1/25 7:10 == 32.6	11/1/25 11:40 == 47.8	11/1/25 16:10 == 32.9
11/1/25 2:45 == 47.9	11/1/25 7:15 == 39.4	11/1/25 11:45 == 47.8	11/1/25 16:15 == 38
11/1/25 2:50 == 47.8	11/1/25 7:20 == 47	11/1/25 11:50 == 47.5	11/1/25 16:20 == 46.4
11/1/25 2:55 == 46.7	11/1/25 7:25 == 48	11/1/25 11:55 == 46.9	11/1/25 16:25 == 47.9
11/1/25 3:00 == 38.5	11/1/25 7:30 == 47.9	11/1/25 12:00 == 40	11/1/25 16:30 == 47.8
11/1/25 3:05 == 32.5	11/1/25 7:35 == 48	11/1/25 12:05 == 32.6	11/1/25 16:35 == 47.9
11/1/25 3:10 == 32.4	11/1/25 7:40 == 47.2	11/1/25 12:10 == 33.1	11/1/25 16:40 == 47.9
11/1/25 3:15 == 32.4	11/1/25 7:45 == 47.3	11/1/25 12:15 == 32.9	11/1/25 16:45 == 47.5
11/1/25 3:20 == 32.5	11/1/25 7:50 == 47.7	11/1/25 12:20 == 32.9	11/1/25 16:50 == 48
11/1/25 3:25 == 32.5	11/1/25 7:55 == 47.6	11/1/25 12:25 == 32.9	11/1/25 16:55 == 46.6
11/1/25 3:30 == 32.6	11/1/25 8:00 == 47.7	11/1/25 12:30 == 32.8	11/1/25 17:00 == 41.2
11/1/25 3:35 == 32.5	11/1/25 8:05 == 48	11/1/25 12:35 == 32.7	11/1/25 17:05 == 32.5
11/1/25 3:40 == 32.5	11/1/25 8:10 == 47.3	11/1/25 12:40 == 32.8	11/1/25 17:10 == 32.6
11/1/25 3:45 == 32.6	11/1/25 8:15 == 39.5	11/1/25 12:45 == 39.8	11/1/25 17:15 == 32.6
11/1/25 3:50 == 32.5	11/1/25 8:20 == 32.6	11/1/25 12:50 == 46.3	11/1/25 17:20 == 32.6
11/1/25 3:55 == 33.4	11/1/25 8:25 == 32.5	11/1/25 12:55 == 48	11/1/25 17:25 == 32.6
11/1/25 4:00 == 38.3	11/1/25 8:30 == 32.5	11/1/25 13:00 == 47.5	11/1/25 17:30 == 32.7
11/1/25 4:05 == 47.4	11/1/25 8:35 == 32.4	11/1/25 13:05 == 47.6	11/1/25 17:35 == 32.5
11/1/25 4:10 == 47.9	11/1/25 8:40 == 32.4	11/1/25 13:10 == 47.9	11/1/25 17:40 == 32.7
11/1/25 4:15 == 48	11/1/25 8:45 == 32.5	11/1/25 13:15 == 48	11/1/25 17:45 == 32.7
11/1/25 4:20 == 48.2	11/1/25 8:50 == 32.6	11/1/25 13:20 == 48	11/1/25 17:50 == 32.7
11/1/25 4:25 == 47.8	11/1/25 8:55 == 32.5	11/1/25 13:25 == 48	11/1/25 17:55 == 32.9

Pumpback Station Discharge (0364)

11/1/25 18:00 == 39.1	11/1/25 22:30 == 32.5	11/2/25 2:00 == 47.9	11/2/25 6:30 == 16.3
11/1/25 18:05 == 46	11/1/25 22:35 == 32.4	11/2/25 2:05 == 47.9	11/2/25 6:35 == 19.1
11/1/25 18:10 == 47.6	11/1/25 22:40 == 32.5	11/2/25 2:10 == 47.3	11/2/25 6:40 == 35.8
11/1/25 18:15 == 47.6	11/1/25 22:45 == 36.4	11/2/25 2:15 == 43.2	11/2/25 6:45 == 47.8
11/1/25 18:20 == 48	11/1/25 22:50 == 46.1	11/2/25 2:20 == 32.4	11/2/25 6:50 == 47.9
11/1/25 18:25 == 47.8	11/1/25 22:55 == 47.8	11/2/25 2:25 == 32.4	11/2/25 6:55 == 48.1
11/1/25 18:30 == 47.7	11/1/25 23:00 == 47.9	11/2/25 2:30 == 32.5	11/2/25 7:00 == 47.9
11/1/25 18:35 == 47.9	11/1/25 23:05 == 48	11/2/25 2:35 == 32.6	11/2/25 7:05 == 47.7
11/1/25 18:40 == 47.8	11/1/25 23:10 == 47.5	11/2/25 2:40 == 32.6	11/2/25 7:10 == 47.9
11/1/25 18:45 == 41	11/1/25 23:15 == 47.7	11/2/25 2:45 == 32.6	11/2/25 7:15 == 47.9
11/1/25 18:50 == 32.7	11/1/25 23:20 == 47.9	11/2/25 2:50 == 32.6	11/2/25 7:20 == 48
11/1/25 18:55 == 32.5	11/1/25 23:25 == 48	11/2/25 2:55 == 32.6	11/2/25 7:25 == 47.8
11/1/25 19:00 == 32.4	11/1/25 23:30 == 47.9	11/2/25 3:00 == 36.3	11/2/25 7:30 == 47.8
11/1/25 19:05 == 32.5	11/1/25 23:35 == 48	11/2/25 3:05 == 46.2	11/2/25 7:35 == 48
11/1/25 19:10 == 32.4	11/1/25 23:40 == 48	11/2/25 3:10 == 47.9	11/2/25 7:40 == 47.9
11/1/25 19:15 == 32.4	11/1/25 23:45 == 40.9	11/2/25 3:15 == 47.8	11/2/25 7:45 == 48
11/1/25 19:20 == 32.4	11/1/25 23:50 == 33.4	11/2/25 3:20 == 47.8	11/2/25 7:50 == 48
11/1/25 19:25 == 32.8	11/1/25 23:55 == 32.5	11/2/25 3:25 == 48	11/2/25 7:55 == 48
11/1/25 19:30 == 35.8	11/2/25 0:00 == 32.5	11/2/25 3:30 == 48	11/2/25 8:00 == 48.1
11/1/25 19:35 == 47.6	11/2/25 0:05 == 32.6	11/2/25 3:35 == 47.9	11/2/25 8:05 == 48
11/1/25 19:40 == 47.9	11/2/25 0:10 == 32.7	11/2/25 3:40 == 47.9	11/2/25 8:10 == 47.9
11/1/25 19:45 == 48	11/2/25 0:15 == 32.8	11/2/25 3:45 == 41	11/2/25 8:15 == 47.9
11/1/25 19:50 == 47.9	11/2/25 0:20 == 32.8	11/2/25 3:50 == 34.1	11/2/25 8:20 == 48
11/1/25 19:55 == 47.5	11/2/25 0:25 == 32.6	11/2/25 3:55 == 32.5	11/2/25 8:25 == 47.9
11/1/25 20:00 == 48	11/2/25 0:30 == 35.8	11/2/25 4:00 == 32.5	11/2/25 8:30 == 47.9
11/1/25 20:05 == 47.9	11/2/25 0:35 == 47.3	11/2/25 4:05 == 32.7	11/2/25 8:35 == 48
11/1/25 20:10 == 48	11/2/25 0:40 == 47.9	11/2/25 4:10 == 32.6	11/2/25 8:40 == 47.9
11/1/25 20:15 == 39.9	11/2/25 0:45 == 48.2	11/2/25 4:15 == 32.5	11/2/25 8:45 == 47
11/1/25 20:20 == 33.6	11/2/25 0:50 == 48.2	11/2/25 4:20 == 32.5	11/2/25 8:50 == 41.3
11/1/25 20:25 == 32.7	11/2/25 0:55 == 47.9	11/2/25 4:25 == 32.5	11/2/25 8:55 == 32.5
11/1/25 20:30 == 32.7	11/2/25 1:00 == 48.2	11/2/25 4:30 == 36	11/2/25 9:00 == 32.6
11/1/25 20:35 == 32.8	11/2/25 1:05 == 47.9	11/2/25 4:35 == 45.6	11/2/25 9:05 == 32.5
11/1/25 20:40 == 32.7	11/2/25 1:10 == 47.9	11/2/25 4:40 == 47.8	11/2/25 9:10 == 32.5
11/1/25 20:45 == 32.6	11/2/25 1:15 == 47.5	11/2/25 4:45 == 47.8	11/2/25 9:15 == 32.5
11/1/25 20:50 == 32.7	11/2/25 1:20 == 47.8	11/2/25 4:50 == 47.2	11/2/25 9:20 == 32.5
11/1/25 20:55 == 32.6	11/2/25 1:25 == 47.5	11/2/25 4:55 == 47.4	11/2/25 9:25 == 32.7
11/1/25 21:00 == 38.4	11/2/25 1:30 == 40.8	11/2/25 5:00 == 47.5	11/2/25 9:30 == 32.8
11/1/25 21:05 == 45	11/2/25 1:35 == 33.8	11/2/25 5:05 == 47.9	11/2/25 9:35 == 36.6
11/1/25 21:10 == 47.4	11/2/25 1:40 == 32.4	11/2/25 5:10 == 47.9	11/2/25 9:40 == 47.4
11/1/25 21:15 == 47.9	11/2/25 1:45 == 32.4	11/2/25 5:15 == 48	11/2/25 9:45 == 48.1
11/1/25 21:20 == 47.8	11/2/25 1:50 == 32.4	11/2/25 5:20 == 47.9	11/2/25 9:50 == 48
11/1/25 21:25 == 47.7	11/2/25 1:55 == 32.6	11/2/25 5:25 == 48.1	11/2/25 9:55 == 48
11/1/25 21:30 == 47.6	11/2/25 1:00 == 32.6	11/2/25 5:30 == 42.6	11/2/25 10:00 == 48.2
11/1/25 21:35 == 47.8	11/2/25 1:05 == 32.5	11/2/25 5:35 == 33.6	11/2/25 10:05 == 48
11/1/25 21:40 == 47.8	11/2/25 1:10 == 32.6	11/2/25 5:40 == 32.5	11/2/25 10:10 == 47.9
11/1/25 21:45 == 47.8	11/2/25 1:15 == 37.5	11/2/25 5:45 == 32.6	11/2/25 10:15 == 48
11/1/25 21:50 == 47.8	11/2/25 1:20 == 44.6	11/2/25 5:50 == 32.6	11/2/25 10:20 == 47.9
11/1/25 21:55 == 47	11/2/25 1:25 == 47.3	11/2/25 5:55 == 32.5	11/2/25 10:25 == 47.9
11/1/25 22:00 == 42.2	11/2/25 1:30 == 47.4	11/2/25 6:00 == 32.4	11/2/25 10:30 == 47.6
11/1/25 22:05 == 32.2	11/2/25 1:35 == 47.9	11/2/25 6:05 == 0	11/2/25 10:35 == 47.6
11/1/25 22:10 == 32.5	11/2/25 1:40 == 48	11/2/25 6:10 == 0	11/2/25 10:40 == 47.6
11/1/25 22:15 == 32.5	11/2/25 1:45 == 47.9	11/2/25 6:15 == 4.4	11/2/25 10:45 == 47.4
11/1/25 22:20 == 32.6	11/2/25 1:50 == 47.8	11/2/25 6:20 == 15.4	11/2/25 10:50 == 39.9
11/1/25 22:25 == 32.5	11/2/25 1:55 == 47.8	11/2/25 6:25 == 16.3	11/2/25 10:55 == 32.9

Pumpback Station Discharge (0364)

11/2/25 11:00 == 32.6	11/2/25 15:30 == 48.1	11/2/25 20:00 == 48	11/3/25 0:30 == 48
11/2/25 11:05 == 32.8	11/2/25 15:35 == 48.1	11/2/25 20:05 == 41.8	11/3/25 0:35 == 48
11/2/25 11:10 == 33	11/2/25 15:40 == 47	11/2/25 20:10 == 33.1	11/3/25 0:40 == 48
11/2/25 11:15 == 33	11/2/25 15:45 == 47	11/2/25 20:15 == 32.5	11/3/25 0:45 == 48
11/2/25 11:20 == 33	11/2/25 15:50 == 47.6	11/2/25 20:20 == 32.6	11/3/25 0:50 == 48
11/2/25 11:25 == 33.1	11/2/25 15:55 == 47.4	11/2/25 20:25 == 32.6	11/3/25 0:55 == 48.1
11/2/25 11:30 == 33.3	11/2/25 16:00 == 47.5	11/2/25 20:30 == 32.5	11/3/25 1:00 == 48
11/2/25 11:35 == 37	11/2/25 16:05 == 41.2	11/2/25 20:35 == 32.6	11/3/25 1:05 == 48
11/2/25 11:40 == 47.2	11/2/25 16:10 == 33.3	11/2/25 20:40 == 32.6	11/3/25 1:10 == 48
11/2/25 11:45 == 48	11/2/25 16:15 == 32.4	11/2/25 20:45 == 32.6	11/3/25 1:15 == 47.9
11/2/25 11:50 == 47.9	11/2/25 16:20 == 32.5	11/2/25 20:50 == 37.4	11/3/25 1:20 == 42.5
11/2/25 11:55 == 47.2	11/2/25 16:25 == 32.6	11/2/25 20:55 == 44.4	11/3/25 1:25 == 33.9
11/2/25 12:00 == 47.4	11/2/25 16:30 == 32.6	11/2/25 21:00 == 47.7	11/3/25 1:30 == 32.5
11/2/25 12:05 == 47.9	11/2/25 16:35 == 32.7	11/2/25 21:05 == 48	11/3/25 1:35 == 32.7
11/2/25 12:10 == 47.5	11/2/25 16:40 == 32.7	11/2/25 21:10 == 47.9	11/3/25 1:40 == 32.6
11/2/25 12:15 == 47.9	11/2/25 16:45 == 32.5	11/2/25 21:15 == 47.9	11/3/25 1:45 == 32.6
11/2/25 12:20 == 48.1	11/2/25 16:50 == 32.6	11/2/25 21:20 == 48	11/3/25 1:50 == 32.7
11/2/25 12:25 == 48.1	11/2/25 16:55 == 32.5	11/2/25 21:25 == 48	11/3/25 1:55 == 32.5
11/2/25 12:30 == 47.9	11/2/25 17:00 == 32.5	11/2/25 21:30 == 47.9	11/3/25 2:00 == 32.6
11/2/25 12:35 == 40.4	11/2/25 17:05 == 32.5	11/2/25 21:35 == 47.9	11/3/25 2:05 == 36.9
11/2/25 12:40 == 34.1	11/2/25 17:10 == 32.6	11/2/25 21:40 == 47.9	11/3/25 2:10 == 44.1
11/2/25 12:45 == 32.8	11/2/25 17:15 == 32.5	11/2/25 21:45 == 47.3	11/3/25 2:15 == 47.6
11/2/25 12:50 == 32.8	11/2/25 17:20 == 35.3	11/2/25 21:50 == 42.9	11/3/25 2:20 == 47.7
11/2/25 12:55 == 32.7	11/2/25 17:25 == 47	11/2/25 21:55 == 32.6	11/3/25 2:25 == 47.4
11/2/25 13:00 == 32.7	11/2/25 17:30 == 47.3	11/2/25 22:00 == 32.7	11/3/25 2:30 == 47.4
11/2/25 13:05 == 32.6	11/2/25 17:35 == 47.9	11/2/25 22:05 == 32.6	11/3/25 2:35 == 47.9
11/2/25 13:10 == 32.6	11/2/25 17:40 == 48	11/2/25 22:10 == 32.5	11/3/25 2:40 == 48
11/2/25 13:15 == 32.7	11/2/25 17:45 == 47.9	11/2/25 22:15 == 32.5	11/3/25 2:45 == 48.1
11/2/25 13:20 == 38.6	11/2/25 17:50 == 48	11/2/25 22:20 == 32.7	11/3/25 2:50 == 47.8
11/2/25 13:25 == 45.7	11/2/25 17:55 == 47.1	11/2/25 22:25 == 32.7	11/3/25 2:55 == 47.5
11/2/25 13:30 == 47.8	11/2/25 18:00 == 47.8	11/2/25 22:30 == 32.5	11/3/25 3:00 == 47.5
11/2/25 13:35 == 47.9	11/2/25 18:05 == 47.9	11/2/25 22:35 == 35.2	11/3/25 3:05 == 43.7
11/2/25 13:40 == 47.9	11/2/25 18:10 == 47.8	11/2/25 22:40 == 46.8	11/3/25 3:10 == 32.7
11/2/25 13:45 == 47.8	11/2/25 18:15 == 47.4	11/2/25 22:45 == 47.7	11/3/25 3:15 == 32.5
11/2/25 13:50 == 47.9	11/2/25 18:20 == 47.7	11/2/25 22:50 == 48.1	11/3/25 3:20 == 32.5
11/2/25 13:55 == 48	11/2/25 18:25 == 47.7	11/2/25 22:55 == 47.4	11/3/25 3:25 == 32.6
11/2/25 14:00 == 48	11/2/25 18:30 == 47.7	11/2/25 23:00 == 47.7	11/3/25 3:30 == 32.5
11/2/25 14:05 == 47.8	11/2/25 18:35 == 41	11/2/25 23:05 == 47.9	11/3/25 3:35 == 32.6
11/2/25 14:10 == 47.9	11/2/25 18:40 == 33.5	11/2/25 23:10 == 47.6	11/3/25 3:40 == 32.6
11/2/25 14:15 == 47.2	11/2/25 18:45 == 32.5	11/2/25 23:15 == 47.8	11/3/25 3:45 == 32.6
11/2/25 14:20 == 42.1	11/2/25 18:50 == 32.6	11/2/25 23:20 == 48.1	11/3/25 3:50 == 34.6
11/2/25 14:25 == 32.4	11/2/25 18:55 == 32.6	11/2/25 23:25 == 47.8	11/3/25 3:55 == 45.8
11/2/25 14:30 == 32.6	11/2/25 19:00 == 32.7	11/2/25 23:30 == 47.9	11/3/25 4:00 == 47.7
11/2/25 14:35 == 32.7	11/2/25 19:05 == 32.6	11/2/25 23:35 == 41.6	11/3/25 4:05 == 47.8
11/2/25 14:40 == 32.5	11/2/25 19:10 == 32.5	11/2/25 23:40 == 34.5	11/3/25 4:10 == 47.5
11/2/25 14:45 == 32.6	11/2/25 19:15 == 32.6	11/2/25 23:45 == 32.6	11/3/25 4:15 == 47.8
11/2/25 14:50 == 32.5	11/2/25 19:20 == 35.7	11/2/25 23:50 == 32.6	11/3/25 4:20 == 47.9
11/2/25 14:55 == 32.6	11/2/25 19:25 == 46.9	11/2/25 23:55 == 32.5	11/3/25 4:25 == 48
11/2/25 15:00 == 32.6	11/2/25 19:30 == 48	11/3/25 0:00 == 32.5	11/3/25 4:30 == 48.1
11/2/25 15:05 == 37.6	11/2/25 19:35 == 47.9	11/3/25 0:05 == 32.5	11/3/25 4:35 == 42.1
11/2/25 15:10 == 46	11/2/25 19:40 == 47.6	11/3/25 0:10 == 32.5	11/3/25 4:40 == 35
11/2/25 15:15 == 47.6	11/2/25 19:45 == 47.9	11/3/25 0:15 == 32.7	11/3/25 4:45 == 32.6
11/2/25 15:20 == 47.9	11/2/25 19:50 == 48	11/3/25 0:20 == 35.9	11/3/25 4:50 == 32.6
11/2/25 15:25 == 48.1	11/2/25 19:55 == 47.2	11/3/25 0:25 == 45.1	11/3/25 4:55 == 32.6

Pumpback Station Discharge (0364)

11/3/25 5:00 == 32.6	11/3/25 9:30 == 47.9	11/3/25 14:00 == 32.5	11/3/25 18:30 == 47.7
11/3/25 5:05 == 32.6	11/3/25 9:35 == 47.5	11/3/25 14:05 == 32.3	11/3/25 18:35 == 47.8
11/3/25 5:10 == 32.6	11/3/25 9:40 == 47.5	11/3/25 14:10 == 46.2	11/3/25 18:40 == 47.7
11/3/25 5:15 == 32.5	11/3/25 9:45 == 47.9	11/3/25 14:15 == 47.2	11/3/25 18:45 == 47.8
11/3/25 5:20 == 32.4	11/3/25 9:50 == 48	11/3/25 14:20 == 47.8	11/3/25 18:50 == 47.2
11/3/25 5:25 == 32.5	11/3/25 9:55 == 47.9	11/3/25 14:25 == 47.9	11/3/25 18:55 == 47.8
11/3/25 5:30 == 32.7	11/3/25 10:00 == 47.8	11/3/25 14:30 == 47.8	11/3/25 19:00 == 47.8
11/3/25 5:35 == 35.5	11/3/25 10:05 == 42.9	11/3/25 14:35 == 47.9	11/3/25 19:05 == 47.9
11/3/25 5:40 == 45.1	11/3/25 10:10 == 35.5	11/3/25 14:40 == 47.8	11/3/25 19:10 == 47.7
11/3/25 5:45 == 47.9	11/3/25 10:15 == 32.7	11/3/25 14:45 == 47.8	11/3/25 19:15 == 47.8
11/3/25 5:50 == 47.6	11/3/25 10:20 == 32.8	11/3/25 14:50 == 42.9	11/3/25 19:20 == 45.8
11/3/25 5:55 == 46.9	11/3/25 10:25 == 32.8	11/3/25 14:55 == 35.4	11/3/25 19:25 == 33.7
11/3/25 6:00 == 47.8	11/3/25 10:30 == 32.8	11/3/25 15:00 == 32.4	11/3/25 19:30 == 32.5
11/3/25 6:05 == 48.1	11/3/25 10:35 == 32.8	11/3/25 15:05 == 32.4	11/3/25 19:35 == 32.5
11/3/25 6:10 == 47.8	11/3/25 10:40 == 33	11/3/25 15:10 == 32.5	11/3/25 19:40 == 32.4
11/3/25 6:15 == 47.8	11/3/25 10:45 == 33.2	11/3/25 15:15 == 32.5	11/3/25 19:45 == 32.5
11/3/25 6:20 == 47.8	11/3/25 10:50 == 35.4	11/3/25 15:20 == 32.5	11/3/25 19:50 == 32.5
11/3/25 6:25 == 48	11/3/25 10:55 == 45.2	11/3/25 15:25 == 32.5	11/3/25 19:55 == 32.5
11/3/25 6:30 == 47.7	11/3/25 11:00 == 48	11/3/25 15:30 == 32.5	11/3/25 20:00 == 32.6
11/3/25 6:35 == 42.8	11/3/25 11:05 == 47.7	11/3/25 15:35 == 35.5	11/3/25 20:05 == 34.6
11/3/25 6:40 == 33.9	11/3/25 11:10 == 47.5	11/3/25 15:40 == 42.9	11/3/25 20:10 == 43
11/3/25 6:45 == 32.6	11/3/25 11:15 == 47.7	11/3/25 15:45 == 47.7	11/3/25 20:15 == 47.8
11/3/25 6:50 == 32.7	11/3/25 11:20 == 48.1	11/3/25 15:50 == 47.9	11/3/25 20:20 == 47.9
11/3/25 6:55 == 32.6	11/3/25 11:25 == 48	11/3/25 15:55 == 48	11/3/25 20:25 == 47.8
11/3/25 7:00 == 32.7	11/3/25 11:30 == 47.8	11/3/25 16:00 == 48	11/3/25 20:30 == 47.7
11/3/25 7:05 == 32.9	11/3/25 11:35 == 48	11/3/25 16:05 == 45.6	11/3/25 20:35 == 47.6
11/3/25 7:10 == 32.6	11/3/25 11:40 == 48	11/3/25 16:10 == 33.4	11/3/25 20:40 == 47.5
11/3/25 7:15 == 32.5	11/3/25 11:45 == 48.1	11/3/25 16:15 == 32.4	11/3/25 20:45 == 47.9
11/3/25 7:20 == 36.5	11/3/25 11:50 == 43.7	11/3/25 16:20 == 32.4	11/3/25 20:50 == 47.8
11/3/25 7:25 == 43.7	11/3/25 11:55 == 34.5	11/3/25 16:25 == 32.4	11/3/25 20:55 == 47.5
11/3/25 7:30 == 47.7	11/3/25 12:00 == 32.6	11/3/25 16:30 == 32.5	11/3/25 21:00 == 48
11/3/25 7:35 == 47.7	11/3/25 12:05 == 32.6	11/3/25 16:35 == 32.5	11/3/25 21:05 == 45.2
11/3/25 7:40 == 47.4	11/3/25 12:10 == 32.5	11/3/25 16:40 == 32.5	11/3/25 21:10 == 35.1
11/3/25 7:45 == 47.7	11/3/25 12:15 == 32.5	11/3/25 16:45 == 32.4	11/3/25 21:15 == 32.3
11/3/25 7:50 == 47.9	11/3/25 12:20 == 32.5	11/3/25 16:50 == 32.6	11/3/25 21:20 == 32.5
11/3/25 7:55 == 47.5	11/3/25 12:25 == 32.4	11/3/25 16:55 == 45.2	11/3/25 21:25 == 32.3
11/3/25 8:00 == 47.5	11/3/25 12:30 == 32.4	11/3/25 17:00 == 47.8	11/3/25 21:30 == 32.4
11/3/25 8:05 == 47.9	11/3/25 12:35 == 35.6	11/3/25 17:05 == 48	11/3/25 21:35 == 32.4
11/3/25 8:10 == 48	11/3/25 12:40 == 43.2	11/3/25 17:10 == 47.6	11/3/25 21:40 == 32.5
11/3/25 8:15 == 47.9	11/3/25 12:45 == 47.9	11/3/25 17:15 == 47.8	11/3/25 21:45 == 32.6
11/3/25 8:20 == 45.2	11/3/25 12:50 == 47.9	11/3/25 17:20 == 48	11/3/25 21:50 == 32.3
11/3/25 8:25 == 32.5	11/3/25 12:55 == 47.9	11/3/25 17:25 == 48	11/3/25 21:55 == 45.3
11/3/25 8:30 == 32.3	11/3/25 13:00 == 47.9	11/3/25 17:30 == 47.9	11/3/25 22:00 == 47.8
11/3/25 8:35 == 32.5	11/3/25 13:05 == 47.9	11/3/25 17:35 == 43.5	11/3/25 22:05 == 47.8
11/3/25 8:40 == 32.5	11/3/25 13:10 == 47.8	11/3/25 17:40 == 36	11/3/25 22:10 == 47.4
11/3/25 8:45 == 32.5	11/3/25 13:15 == 47.8	11/3/25 17:45 == 32.5	11/3/25 22:15 == 47.7
11/3/25 8:50 == 32.5	11/3/25 13:20 == 47.8	11/3/25 17:50 == 32.7	11/3/25 22:20 == 48
11/3/25 8:55 == 32.6	11/3/25 13:25 == 47.8	11/3/25 17:55 == 32.7	11/3/25 22:25 == 47.5
11/3/25 9:00 == 32.6	11/3/25 13:30 == 47.8	11/3/25 18:00 == 32.5	11/3/25 22:30 == 47.5
11/3/25 9:05 == 33.7	11/3/25 13:35 == 45.8	11/3/25 18:05 == 35.4	11/3/25 22:35 == 47.7
11/3/25 9:10 == 45.8	11/3/25 13:40 == 32.6	11/3/25 18:10 == 42.5	11/3/25 22:40 == 47.6
11/3/25 9:15 == 47.8	11/3/25 13:45 == 32.4	11/3/25 18:15 == 47.5	11/3/25 22:45 == 47.8
11/3/25 9:20 == 47.9	11/3/25 13:50 == 32.3	11/3/25 18:20 == 47.9	11/3/25 22:50 == 43.8
11/3/25 9:25 == 47.8	11/3/25 13:55 == 32.4	11/3/25 18:25 == 47.6	11/3/25 22:55 == 36.4

Pumpback Station Discharge (0364)

11/3/25 23:00 == 32.5	11/4/25 3:30 == 47.8	11/4/25 8:00 == 32.5	11/4/25 12:30 == 47.9
11/3/25 23:05 == 32.5	11/4/25 3:35 == 48	11/4/25 8:05 == 32.5	11/4/25 12:35 == 45.7
11/3/25 23:10 == 32.5	11/4/25 3:40 == 47.9	11/4/25 8:10 == 32.4	11/4/25 12:40 == 37.3
11/3/25 23:15 == 32.4	11/4/25 3:45 == 47.9	11/4/25 8:15 == 32.3	11/4/25 12:45 == 32.4
11/3/25 23:20 == 32.4	11/4/25 3:50 == 47.8	11/4/25 8:20 == 32.6	11/4/25 12:50 == 32.3
11/3/25 23:25 == 32.4	11/4/25 3:55 == 47.4	11/4/25 8:25 == 42.7	11/4/25 12:55 == 32.3
11/3/25 23:30 == 32.4	11/4/25 4:00 == 47.6	11/4/25 8:30 == 47	11/4/25 13:00 == 32.4
11/3/25 23:35 == 34.7	11/4/25 4:05 == 47.9	11/4/25 8:35 == 47.7	11/4/25 13:05 == 32.5
11/3/25 23:40 == 42.5	11/4/25 4:10 == 47.3	11/4/25 8:40 == 47.7	11/4/25 13:10 == 32.4
11/3/25 23:45 == 47.4	11/4/25 4:15 == 47.3	11/4/25 8:45 == 47.6	11/4/25 13:15 == 32.2
11/3/25 23:50 == 47.9	11/4/25 4:20 == 44.6	11/4/25 8:50 == 47.7	11/4/25 13:20 == 32.3
11/3/25 23:55 == 48	11/4/25 4:25 == 37.1	11/4/25 8:55 == 47.8	11/4/25 13:25 == 41.9
11/4/25 0:00 == 47.8	11/4/25 4:30 == 32.5	11/4/25 9:00 == 47.9	11/4/25 13:30 == 47.1
11/4/25 0:05 == 48	11/4/25 4:35 == 32.4	11/4/25 9:05 == 47.7	11/4/25 13:35 == 47.7
11/4/25 0:10 == 47.3	11/4/25 4:40 == 32.4	11/4/25 9:10 == 47.6	11/4/25 13:40 == 47.8
11/4/25 0:15 == 48	11/4/25 4:45 == 32.3	11/4/25 9:15 == 47.6	11/4/25 13:45 == 47.8
11/4/25 0:20 == 47.9	11/4/25 4:50 == 32.5	11/4/25 9:20 == 44.8	11/4/25 13:50 == 47.8
11/4/25 0:25 == 48.1	11/4/25 4:55 == 32.5	11/4/25 9:25 == 37.5	11/4/25 13:55 == 47.5
11/4/25 0:30 == 47.8	11/4/25 5:00 == 32.5	11/4/25 9:30 == 32.4	11/4/25 14:00 == 47.6
11/4/25 0:35 == 46.6	11/4/25 5:05 == 33.7	11/4/25 9:35 == 32.5	11/4/25 14:05 == 47.7
11/4/25 0:40 == 34.4	11/4/25 5:10 == 42.3	11/4/25 9:40 == 32.3	11/4/25 14:10 == 47.7
11/4/25 0:45 == 32.5	11/4/25 5:15 == 47.4	11/4/25 9:45 == 32.4	11/4/25 14:15 == 47.8
11/4/25 0:50 == 32.4	11/4/25 5:20 == 48.1	11/4/25 9:50 == 34	11/4/25 14:20 == 47.7
11/4/25 0:55 == 32.4	11/4/25 5:25 == 47.4	11/4/25 9:55 == 40.6	11/4/25 14:25 == 47.7
11/4/25 1:00 == 32.5	11/4/25 5:30 == 47.9	11/4/25 10:00 == 47.8	11/4/25 14:30 == 47.7
11/4/25 1:05 == 32.5	11/4/25 5:35 == 47.8	11/4/25 10:05 == 47.8	11/4/25 14:35 == 45
11/4/25 1:10 == 32.5	11/4/25 5:40 == 47.4	11/4/25 10:10 == 47.1	11/4/25 14:40 == 37.8
11/4/25 1:15 == 32.5	11/4/25 5:45 == 47.9	11/4/25 10:15 == 47.9	11/4/25 14:45 == 32.3
11/4/25 1:20 == 34.1	11/4/25 5:50 == 46.8	11/4/25 10:20 == 48	11/4/25 14:50 == 32.3
11/4/25 1:25 == 42.3	11/4/25 5:55 == 34.9	11/4/25 10:25 == 47.9	11/4/25 14:55 == 32.3
11/4/25 1:30 == 47.9	11/4/25 6:00 == 32.5	11/4/25 10:30 == 47.9	11/4/25 15:00 == 32.4
11/4/25 1:35 == 47.9	11/4/25 6:05 == 32.4	11/4/25 10:35 == 47.8	11/4/25 15:05 == 32.4
11/4/25 1:40 == 47.9	11/4/25 6:10 == 32.5	11/4/25 10:40 == 47.9	11/4/25 15:10 == 32.4
11/4/25 1:45 == 47.7	11/4/25 6:15 == 32.5	11/4/25 10:45 == 48.1	11/4/25 15:15 == 32.6
11/4/25 1:50 == 47.4	11/4/25 6:20 == 32.6	11/4/25 10:50 == 48	11/4/25 15:20 == 33.5
11/4/25 1:55 == 47.3	11/4/25 6:25 == 32.6	11/4/25 10:55 == 34.2	11/4/25 15:25 == 40.3
11/4/25 2:00 == 47.7	11/4/25 6:30 == 32.5	11/4/25 11:00 == 32.4	11/4/25 15:30 == 47.3
11/4/25 2:05 == 47.7	11/4/25 6:35 == 34.1	11/4/25 11:05 == 32.3	11/4/25 15:35 == 48
11/4/25 2:10 == 47.7	11/4/25 6:40 == 41.9	11/4/25 11:10 == 32.7	11/4/25 15:40 == 47.6
11/4/25 2:15 == 47.8	11/4/25 6:45 == 47.9	11/4/25 11:15 == 32.5	11/4/25 15:45 == 47.8
11/4/25 2:20 == 45.3	11/4/25 6:50 == 47.8	11/4/25 11:20 == 32.4	11/4/25 15:50 == 47.9
11/4/25 2:25 == 35.3	11/4/25 6:55 == 47.8	11/4/25 11:25 == 32.6	11/4/25 15:55 == 47.9
11/4/25 2:30 == 32.5	11/4/25 7:00 == 47.9	11/4/25 11:30 == 32.5	11/4/25 16:00 == 47.8
11/4/25 2:35 == 32.5	11/4/25 7:05 == 47.7	11/4/25 11:35 == 33.3	11/4/25 16:05 == 48
11/4/25 2:40 == 32.4	11/4/25 7:10 == 47.5	11/4/25 11:40 == 41.4	11/4/25 16:10 == 47.7
11/4/25 2:45 == 32.4	11/4/25 7:15 == 47.7	11/4/25 11:45 == 47.4	11/4/25 16:15 == 47.9
11/4/25 2:50 == 32.4	11/4/25 7:20 == 47.8	11/4/25 11:50 == 47.7	11/4/25 16:20 == 47.6
11/4/25 2:55 == 32.2	11/4/25 7:25 == 48	11/4/25 11:55 == 47.4	11/4/25 16:25 == 36.2
11/4/25 3:00 == 32.6	11/4/25 7:30 == 47.9	11/4/25 12:00 == 47.6	11/4/25 16:30 == 32.4
11/4/25 3:05 == 32.4	11/4/25 7:35 == 46	11/4/25 12:05 == 48	11/4/25 16:35 == 32.5
11/4/25 3:10 == 43.8	11/4/25 7:40 == 36.2	11/4/25 12:10 == 47.9	11/4/25 16:40 == 32.3
11/4/25 3:15 == 47.4	11/4/25 7:45 == 32.3	11/4/25 12:15 == 47.9	11/4/25 16:45 == 32.3
11/4/25 3:20 == 47.8	11/4/25 7:50 == 32.5	11/4/25 12:20 == 47.9	11/4/25 16:50 == 32.5
11/4/25 3:25 == 47.4	11/4/25 7:55 == 32.4	11/4/25 12:25 == 47.8	11/4/25 16:55 == 32.5

Pumpback Station Discharge (0364)

11/4/25 17:00 == 32.5	11/4/25 21:30 == 32.7	11/5/25 2:00 == 32.4	11/5/25 6:30 == 47.8
11/4/25 17:05 == 33.4	11/4/25 21:35 == 32.2	11/5/25 2:05 == 32.3	11/5/25 6:35 == 46.4
11/4/25 17:10 == 39.9	11/4/25 21:40 == 32.4	11/5/25 2:10 == 39.2	11/5/25 6:40 == 40.1
11/4/25 17:15 == 47.2	11/4/25 21:45 == 32.5	11/5/25 2:15 == 47.1	11/5/25 6:45 == 32.5
11/4/25 17:20 == 47.9	11/4/25 21:50 == 32.6	11/5/25 2:20 == 47.7	11/5/25 6:50 == 32.4
11/4/25 17:25 == 47.9	11/4/25 21:55 == 32.6	11/5/25 2:25 == 47.2	11/5/25 6:55 == 32.4
11/4/25 17:30 == 47.8	11/4/25 22:00 == 32.6	11/5/25 2:30 == 47.6	11/5/25 7:00 == 32.4
11/4/25 17:35 == 47.9	11/4/25 22:05 == 32.5	11/5/25 2:35 == 47.8	11/5/25 7:05 == 32.4
11/4/25 17:40 == 47.8	11/4/25 22:10 == 39.7	11/5/25 2:40 == 48	11/5/25 7:10 == 32.5
11/4/25 17:45 == 47.8	11/4/25 22:15 == 47.1	11/5/25 2:45 == 47.9	11/5/25 7:15 == 32.4
11/4/25 17:50 == 47.5	11/4/25 22:20 == 47.6	11/5/25 2:50 == 47.8	11/5/25 7:20 == 32.5
11/4/25 17:55 == 47.4	11/4/25 22:25 == 47.6	11/5/25 2:55 == 47.5	11/5/25 7:25 == 39.2
11/4/25 18:00 == 47.8	11/4/25 22:30 == 47.6	11/5/25 3:00 == 47.6	11/5/25 7:30 == 46.3
11/4/25 18:05 == 47.1	11/4/25 22:35 == 47.6	11/5/25 3:05 == 47.1	11/5/25 7:35 == 47.8
11/4/25 18:10 == 36.9	11/4/25 22:40 == 47.6	11/5/25 3:10 == 38.5	11/5/25 7:40 == 48
11/4/25 18:15 == 32.5	11/4/25 22:45 == 47.9	11/5/25 3:15 == 32.4	11/5/25 7:45 == 47.9
11/4/25 18:20 == 32.5	11/4/25 22:50 == 47.9	11/5/25 3:20 == 32.5	11/5/25 7:50 == 47.8
11/4/25 18:25 == 32.2	11/4/25 22:55 == 47.8	11/5/25 3:25 == 32.5	11/5/25 7:55 == 47.2
11/4/25 18:30 == 32.2	11/4/25 23:00 == 47.7	11/5/25 3:30 == 32.3	11/5/25 8:00 == 47.6
11/4/25 18:35 == 32.4	11/4/25 23:05 == 47.8	11/5/25 3:35 == 32.4	11/5/25 8:05 == 47.7
11/4/25 18:40 == 32.4	11/4/25 23:10 == 47.8	11/5/25 3:40 == 32.4	11/5/25 8:10 == 47.8
11/4/25 18:45 == 32.5	11/4/25 23:15 == 47.8	11/5/25 3:45 == 32.4	11/5/25 8:15 == 47.7
11/4/25 18:50 == 32.5	11/4/25 23:20 == 47.4	11/5/25 3:50 == 32.9	11/5/25 8:20 == 47.7
11/4/25 18:55 == 41.9	11/4/25 23:25 == 37.5	11/5/25 3:55 == 38	11/5/25 8:25 == 39.4
11/4/25 19:00 == 47.1	11/4/25 23:30 == 32.5	11/5/25 4:00 == 47.7	11/5/25 8:30 == 32.3
11/4/25 19:05 == 48	11/4/25 23:35 == 32.5	11/5/25 4:05 == 47.8	11/5/25 8:35 == 32.3
11/4/25 19:10 == 47.8	11/4/25 23:40 == 32.4	11/5/25 4:10 == 47.4	11/5/25 8:40 == 32.3
11/4/25 19:15 == 47.9	11/4/25 23:45 == 32.5	11/5/25 4:15 == 47.3	11/5/25 8:45 == 32.4
11/4/25 19:20 == 47.9	11/4/25 23:50 == 32.5	11/5/25 4:20 == 47.9	11/5/25 8:50 == 32.4
11/4/25 19:25 == 47.6	11/4/25 23:55 == 32.4	11/5/25 4:25 == 47.7	11/5/25 8:55 == 32.4
11/4/25 19:30 == 47.7	11/5/25 0:00 == 32.4	11/5/25 4:30 == 48.1	11/5/25 9:00 == 32.5
11/4/25 19:35 == 47.9	11/5/25 0:05 == 32.6	11/5/25 4:35 == 47.6	11/5/25 9:05 == 32.7
11/4/25 19:40 == 47.7	11/5/25 0:10 == 40.2	11/5/25 4:40 == 47.3	11/5/25 9:10 == 36.8
11/4/25 19:45 == 47.7	11/5/25 0:15 == 46.3	11/5/25 4:45 == 47.8	11/5/25 9:15 == 47.2
11/4/25 19:50 == 45.7	11/5/25 0:20 == 47.9	11/5/25 4:50 == 47.9	11/5/25 9:20 == 47.7
11/4/25 19:55 == 38.6	11/5/25 0:25 == 48	11/5/25 4:55 == 38.3	11/5/25 9:25 == 47.6
11/4/25 20:00 == 32.2	11/5/25 0:30 == 47.9	11/5/25 5:00 == 33.2	11/5/25 9:30 == 47.8
11/4/25 20:05 == 32.3	11/5/25 0:35 == 47.7	11/5/25 5:05 == 32.4	11/5/25 9:35 == 47.8
11/4/25 20:10 == 32.5	11/5/25 0:40 == 47.9	11/5/25 5:10 == 32.5	11/5/25 9:40 == 47.7
11/4/25 20:15 == 32.5	11/5/25 0:45 == 48	11/5/25 5:15 == 32.4	11/5/25 9:45 == 47.7
11/4/25 20:20 == 32.4	11/5/25 0:50 == 48	11/5/25 5:20 == 32.6	11/5/25 9:50 == 47.8
11/4/25 20:25 == 32.4	11/5/25 0:55 == 47.9	11/5/25 5:25 == 32.5	11/5/25 9:55 == 46.6
11/4/25 20:30 == 32.4	11/5/25 1:00 == 47.8	11/5/25 5:30 == 32.4	11/5/25 10:00 == 47.6
11/4/25 20:35 == 33.1	11/5/25 1:05 == 47.7	11/5/25 5:35 == 32.5	11/5/25 10:05 == 47.8
11/4/25 20:40 == 39.2	11/5/25 1:10 == 47.6	11/5/25 5:40 == 39.4	11/5/25 10:10 == 38.6
11/4/25 20:45 == 47.8	11/5/25 1:15 == 47.7	11/5/25 5:45 == 46.1	11/5/25 10:15 == 33.2
11/4/25 20:50 == 47.4	11/5/25 1:20 == 46.1	11/5/25 5:50 == 47.9	11/5/25 10:20 == 32.2
11/4/25 20:55 == 47.8	11/5/25 1:25 == 39.5	11/5/25 5:55 == 47.8	11/5/25 10:25 == 32.5
11/4/25 21:00 == 47.8	11/5/25 1:30 == 32.4	11/5/25 6:00 == 47.6	11/5/25 10:30 == 32.5
11/4/25 21:05 == 48	11/5/25 1:35 == 32.4	11/5/25 6:05 == 47.6	11/5/25 10:35 == 32.5
11/4/25 21:10 == 47.9	11/5/25 1:40 == 32.4	11/5/25 6:10 == 47.5	11/5/25 10:40 == 32.5
11/4/25 21:15 == 47.7	11/5/25 1:45 == 32.4	11/5/25 6:15 == 47.6	11/5/25 10:45 == 32.4
11/4/25 21:20 == 47.7	11/5/25 1:50 == 32.4	11/5/25 6:20 == 47.8	11/5/25 10:50 == 32.7
11/4/25 21:25 == 36.6	11/5/25 1:55 == 32.1	11/5/25 6:25 == 47.9	11/5/25 10:55 == 39.6

Pumpback Station Discharge (0364)

11/5/25 11:00 == 46.2	11/5/25 15:30 == 32.6	11/5/25 20:00 == 48	11/6/25 0:30 == 32.5
11/5/25 11:05 == 47.4	11/5/25 15:35 == 32.6	11/5/25 20:05 == 47.9	11/6/25 0:35 == 32.4
11/5/25 11:10 == 47.4	11/5/25 15:40 == 32.5	11/5/25 20:10 == 47.6	11/6/25 0:40 == 32.4
11/5/25 11:15 == 47.7	11/5/25 15:45 == 32.5	11/5/25 20:15 == 47.8	11/6/25 0:45 == 32.5
11/5/25 11:20 == 47.7	11/5/25 15:50 == 32.7	11/5/25 20:20 == 47.9	11/6/25 0:50 == 32.5
11/5/25 11:25 == 47.7	11/5/25 15:55 == 38.5	11/5/25 20:25 == 48.1	11/6/25 0:55 == 34.5
11/5/25 11:30 == 48.1	11/5/25 16:00 == 45.4	11/5/25 20:30 == 47.9	11/6/25 1:00 == 47.2
11/5/25 11:35 == 48	11/5/25 16:05 == 47.9	11/5/25 20:35 == 47.8	11/6/25 1:05 == 47.7
11/5/25 11:40 == 48.1	11/5/25 16:10 == 48	11/5/25 20:40 == 40.3	11/6/25 1:10 == 48.1
11/5/25 11:45 == 48.1	11/5/25 16:15 == 48	11/5/25 20:45 == 34.2	11/6/25 1:15 == 47.9
11/5/25 11:50 == 46.8	11/5/25 16:20 == 48	11/5/25 20:50 == 33	11/6/25 1:20 == 47.9
11/5/25 11:55 == 40.8	11/5/25 16:25 == 48	11/5/25 20:55 == 32.6	11/6/25 1:25 == 48
11/5/25 12:00 == 32.6	11/5/25 16:30 == 48	11/5/25 21:00 == 32.5	11/6/25 1:30 == 47.8
11/5/25 12:05 == 32.7	11/5/25 16:35 == 47.6	11/5/25 21:05 == 32.6	11/6/25 1:35 == 48
11/5/25 12:10 == 32.4	11/5/25 16:40 == 47.4	11/5/25 21:10 == 32.7	11/6/25 1:40 == 47.9
11/5/25 12:15 == 32.6	11/5/25 16:45 == 48	11/5/25 21:15 == 32.8	11/6/25 1:45 == 47.9
11/5/25 12:20 == 32.7	11/5/25 16:50 == 47.1	11/5/25 21:20 == 32.8	11/6/25 1:50 == 47.9
11/5/25 12:25 == 32.7	11/5/25 16:55 == 42.2	11/5/25 21:25 == 37.7	11/6/25 1:55 == 40.8
11/5/25 12:30 == 32.8	11/5/25 17:00 == 32.3	11/5/25 21:30 == 45.1	11/6/25 2:00 == 34.2
11/5/25 12:35 == 32.6	11/5/25 17:05 == 32.6	11/5/25 21:35 == 47.8	11/6/25 2:05 == 32.5
11/5/25 12:40 == 38.3	11/5/25 17:10 == 32.5	11/5/25 21:40 == 47.7	11/6/25 2:10 == 32.3
11/5/25 12:45 == 46	11/5/25 17:15 == 32.5	11/5/25 21:45 == 47.9	11/6/25 2:15 == 32.4
11/5/25 12:50 == 48	11/5/25 17:20 == 32.5	11/5/25 21:50 == 48.1	11/6/25 2:20 == 32.7
11/5/25 12:55 == 47.9	11/5/25 17:25 == 32.9	11/5/25 21:55 == 48	11/6/25 2:25 == 32.6
11/5/25 13:00 == 47.9	11/5/25 17:30 == 32.8	11/5/25 22:00 == 48.1	11/6/25 2:30 == 32.5
11/5/25 13:05 == 48	11/5/25 17:35 == 32.5	11/5/25 22:05 == 47.8	11/6/25 2:35 == 32.4
11/5/25 13:10 == 47.8	11/5/25 17:40 == 36.6	11/5/25 22:10 == 47.8	11/6/25 2:40 == 37.2
11/5/25 13:15 == 48	11/5/25 17:45 == 47.3	11/5/25 22:15 == 47.8	11/6/25 2:45 == 45
11/5/25 13:20 == 48.1	11/5/25 17:50 == 47.9	11/5/25 22:20 == 47.4	11/6/25 2:50 == 47.9
11/5/25 13:25 == 47.9	11/5/25 17:55 == 47.8	11/5/25 22:25 == 42.1	11/6/25 2:55 == 47.9
11/5/25 13:30 == 48	11/5/25 18:00 == 48	11/5/25 22:30 == 32.4	11/6/25 3:00 == 48
11/5/25 13:35 == 48	11/5/25 18:05 == 48	11/5/25 22:35 == 32.5	11/6/25 3:05 == 48
11/5/25 13:40 == 40.2	11/5/25 18:10 == 47.3	11/5/25 22:40 == 32.4	11/6/25 3:10 == 48
11/5/25 13:45 == 32.7	11/5/25 18:15 == 47.6	11/5/25 22:45 == 32.5	11/6/25 3:15 == 48
11/5/25 13:50 == 32.7	11/5/25 18:20 == 47.8	11/5/25 22:50 == 32.5	11/6/25 3:20 == 47.4
11/5/25 13:55 == 32.6	11/5/25 18:25 == 47.9	11/5/25 22:55 == 32.6	11/6/25 3:25 == 43.3
11/5/25 14:00 == 32.6	11/5/25 18:30 == 48	11/5/25 23:00 == 32.5	11/6/25 3:30 == 32.5
11/5/25 14:05 == 32.8	11/5/25 18:35 == 48	11/5/25 23:05 == 32.5	11/6/25 3:35 == 32.5
11/5/25 14:10 == 32.9	11/5/25 18:40 == 40.2	11/5/25 23:10 == 36.9	11/6/25 3:40 == 32.6
11/5/25 14:15 == 32.7	11/5/25 18:45 == 33.3	11/5/25 23:15 == 45.9	11/6/25 3:45 == 32.4
11/5/25 14:20 == 33	11/5/25 18:50 == 32.4	11/5/25 23:20 == 48	11/6/25 3:50 == 32.6
11/5/25 14:25 == 36.5	11/5/25 18:55 == 32.5	11/5/25 23:25 == 47.8	11/6/25 3:55 == 32.6
11/5/25 14:30 == 47.3	11/5/25 19:00 == 32.5	11/5/25 23:30 == 47.8	11/6/25 4:00 == 32.5
11/5/25 14:35 == 47.9	11/5/25 19:05 == 32.5	11/5/25 23:35 == 47.8	11/6/25 4:05 == 32.6
11/5/25 14:40 == 48.1	11/5/25 19:10 == 32.6	11/5/25 23:40 == 47.8	11/6/25 4:10 == 35.6
11/5/25 14:45 == 48.1	11/5/25 19:15 == 32.6	11/5/25 23:45 == 48	11/6/25 4:15 == 45.7
11/5/25 14:50 == 47.9	11/5/25 19:20 == 32.6	11/5/25 23:50 == 47.9	11/6/25 4:20 == 47.8
11/5/25 14:55 == 47.8	11/5/25 19:25 == 36.5	11/5/25 23:55 == 47.8	11/6/25 4:25 == 47.8
11/5/25 15:00 == 48	11/5/25 19:30 == 47.4	11/6/25 0:00 == 47.9	11/6/25 4:30 == 48.1
11/5/25 15:05 == 47.9	11/5/25 19:35 == 48	11/6/25 0:05 == 47.9	11/6/25 4:35 == 47.9
11/5/25 15:10 == 39.4	11/5/25 19:40 == 47.9	11/6/25 0:10 == 41.7	11/6/25 4:40 == 47.9
11/5/25 15:15 == 33.3	11/5/25 19:45 == 48.1	11/6/25 0:15 == 33.2	11/6/25 4:45 == 47.8
11/5/25 15:20 == 32.6	11/5/25 19:50 == 48	11/6/25 0:20 == 32.4	11/6/25 4:50 == 47.9
11/5/25 15:25 == 32.7	11/5/25 19:55 == 47.8	11/6/25 0:25 == 32.4	11/6/25 4:55 == 41.4

Pumpback Station Discharge (0364)

11/6/25 5:00 == 34.4	11/6/25 9:30 == 47.7	11/6/25 14:00 == 47.7	11/6/25 18:30 == 32.4
11/6/25 5:05 == 32.5	11/6/25 9:35 == 47.7	11/6/25 14:05 == 47.8	11/6/25 18:35 == 32.3
11/6/25 5:10 == 32.5	11/6/25 9:40 == 47.8	11/6/25 14:10 == 47.5	11/6/25 18:40 == 32.3
11/6/25 5:15 == 32.5	11/6/25 9:45 == 47.8	11/6/25 14:15 == 47.7	11/6/25 18:45 == 32.3
11/6/25 5:20 == 32.6	11/6/25 9:50 == 47.8	11/6/25 14:20 == 47.6	11/6/25 18:50 == 32.4
11/6/25 5:25 == 32.6	11/6/25 9:55 == 47.5	11/6/25 14:25 == 43.9	11/6/25 18:55 == 34
11/6/25 5:30 == 32.5	11/6/25 10:00 == 47.4	11/6/25 14:30 == 33.3	11/6/25 19:00 == 44.1
11/6/25 5:35 == 32.5	11/6/25 10:05 == 47.5	11/6/25 14:35 == 32.3	11/6/25 19:05 == 47.8
11/6/25 5:40 == 35.9	11/6/25 10:10 == 47.3	11/6/25 14:40 == 32.4	11/6/25 19:10 == 47.9
11/6/25 5:45 == 44.9	11/6/25 10:15 == 47.6	11/6/25 14:45 == 32.4	11/6/25 19:15 == 48
11/6/25 5:50 == 47.9	11/6/25 10:20 == 47.9	11/6/25 14:50 == 32.4	11/6/25 19:20 == 47.6
11/6/25 5:55 == 48	11/6/25 10:25 == 42.2	11/6/25 14:55 == 32.3	11/6/25 19:25 == 47.4
11/6/25 6:00 == 48.1	11/6/25 10:30 == 34.4	11/6/25 15:00 == 32.3	11/6/25 19:30 == 47.6
11/6/25 6:05 == 47.9	11/6/25 10:35 == 32.6	11/6/25 15:05 == 32.4	11/6/25 19:35 == 47.9
11/6/25 6:10 == 47.9	11/6/25 10:40 == 32.6	11/6/25 15:10 == 35.5	11/6/25 19:40 == 47.9
11/6/25 6:15 == 47.9	11/6/25 10:45 == 32.7	11/6/25 15:15 == 43.4	11/6/25 19:45 == 48.1
11/6/25 6:20 == 47.8	11/6/25 10:50 == 32.5	11/6/25 15:20 == 47.6	11/6/25 19:50 == 47.8
11/6/25 6:25 == 48.1	11/6/25 10:55 == 32.1	11/6/25 15:25 == 47.7	11/6/25 19:55 == 47.7
11/6/25 6:30 == 48	11/6/25 11:00 == 32.6	11/6/25 15:30 == 47.8	11/6/25 20:00 == 47.8
11/6/25 6:35 == 47.7	11/6/25 11:05 == 32.5	11/6/25 15:35 == 47.7	11/6/25 20:05 == 47.5
11/6/25 6:40 == 42.1	11/6/25 11:10 == 32.5	11/6/25 15:40 == 47.5	11/6/25 20:10 == 43.3
11/6/25 6:45 == 33.6	11/6/25 11:15 == 32.4	11/6/25 15:45 == 47.6	11/6/25 20:15 == 35.4
11/6/25 6:50 == 32.6	11/6/25 11:20 == 32.4	11/6/25 15:50 == 47.8	11/6/25 20:20 == 32.3
11/6/25 6:55 == 32.7	11/6/25 11:25 == 33.2	11/6/25 15:55 == 47.8	11/6/25 20:25 == 32.3
11/6/25 7:00 == 32.6	11/6/25 11:30 == 46.6	11/6/25 16:00 == 47.8	11/6/25 20:30 == 32.4
11/6/25 7:05 == 32.8	11/6/25 11:35 == 48.1	11/6/25 16:05 == 47.6	11/6/25 20:35 == 32.6
11/6/25 7:10 == 32.8	11/6/25 11:40 == 47.2	11/6/25 16:10 == 44.5	11/6/25 20:40 == 35.3
11/6/25 7:15 == 32.8	11/6/25 11:45 == 47.6	11/6/25 16:15 == 33.5	11/6/25 20:45 == 42.2
11/6/25 7:20 == 32.9	11/6/25 11:50 == 48	11/6/25 16:20 == 32.3	11/6/25 20:50 == 47.4
11/6/25 7:25 == 36.9	11/6/25 11:55 == 47.8	11/6/25 16:25 == 32.3	11/6/25 20:55 == 47.8
11/6/25 7:30 == 44.1	11/6/25 12:00 == 47.8	11/6/25 16:30 == 32.4	11/6/25 21:00 == 47.8
11/6/25 7:35 == 47.7	11/6/25 12:05 == 46.8	11/6/25 16:35 == 32.5	11/6/25 21:05 == 47.8
11/6/25 7:40 == 47.9	11/6/25 12:10 == 47	11/6/25 16:40 == 32.5	11/6/25 21:10 == 47.7
11/6/25 7:45 == 47.9	11/6/25 12:15 == 47.4	11/6/25 16:45 == 32.4	11/6/25 21:15 == 47.6
11/6/25 7:50 == 47.8	11/6/25 12:20 == 47.6	11/6/25 16:50 == 32.5	11/6/25 21:20 == 47.6
11/6/25 7:55 == 47.8	11/6/25 12:25 == 42.5	11/6/25 16:55 == 32.5	11/6/25 21:25 == 47.5
11/6/25 8:00 == 47.9	11/6/25 12:30 == 35.2	11/6/25 17:00 == 32.3	11/6/25 21:30 == 47.6
11/6/25 8:05 == 47.8	11/6/25 12:35 == 32.4	11/6/25 17:05 == 32.4	11/6/25 21:35 == 47.6
11/6/25 8:10 == 47.7	11/6/25 12:40 == 32.2	11/6/25 17:10 == 33.6	11/6/25 21:40 == 46.3
11/6/25 8:15 == 47.9	11/6/25 12:45 == 32.3	11/6/25 17:15 == 44.6	11/6/25 21:45 == 32.6
11/6/25 8:20 == 47.9	11/6/25 12:50 == 32.3	11/6/25 17:20 == 47.6	11/6/25 21:50 == 32.2
11/6/25 8:25 == 44.2	11/6/25 12:55 == 32.4	11/6/25 17:25 == 47.9	11/6/25 21:55 == 32.6
11/6/25 8:30 == 32.5	11/6/25 13:00 == 32.5	11/6/25 17:30 == 47.9	11/6/25 22:00 == 32.4
11/6/25 8:35 == 32.5	11/6/25 13:05 == 32.4	11/6/25 17:35 == 47.9	11/6/25 22:05 == 32.4
11/6/25 8:40 == 32.4	11/6/25 13:10 == 35.8	11/6/25 17:40 == 47.9	11/6/25 22:10 == 32.4
11/6/25 8:45 == 32.4	11/6/25 13:15 == 43.4	11/6/25 17:45 == 47.9	11/6/25 22:15 == 32.5
11/6/25 8:50 == 32.4	11/6/25 13:20 == 47.6	11/6/25 17:50 == 48	11/6/25 22:20 == 32.4
11/6/25 8:55 == 32.2	11/6/25 13:25 == 47.8	11/6/25 17:55 == 47.7	11/6/25 22:25 == 33.4
11/6/25 9:00 == 32.2	11/6/25 13:30 == 47.8	11/6/25 18:00 == 47.7	11/6/25 22:30 == 44.5
11/6/25 9:05 == 32.3	11/6/25 13:35 == 47.7	11/6/25 18:05 == 47.9	11/6/25 22:35 == 47.7
11/6/25 9:10 == 32.7	11/6/25 13:40 == 47.8	11/6/25 18:10 == 42.9	11/6/25 22:40 == 47.7
11/6/25 9:15 == 46.2	11/6/25 13:45 == 47.6	11/6/25 18:15 == 35.1	11/6/25 22:45 == 47.6
11/6/25 9:20 == 47.5	11/6/25 13:50 == 47.9	11/6/25 18:20 == 32.2	11/6/25 22:50 == 47.8
11/6/25 9:25 == 47.7	11/6/25 13:55 == 47.7	11/6/25 18:25 == 32.2	11/6/25 22:55 == 47.8

Pumpback Station Discharge (0364)

11/6/25 23:00 == 47.7	11/7/25 3:30 == 32.4	11/7/25 8:00 == 47.6	11/7/25 12:30 == 40.6
11/6/25 23:05 == 47.8	11/7/25 3:35 == 32.2	11/7/25 8:05 == 47.8	11/7/25 12:35 == 47.9
11/6/25 23:10 == 47.5	11/7/25 3:40 == 32.9	11/7/25 8:10 == 47.4	11/7/25 12:40 == 47.9
11/6/25 23:15 == 47.6	11/7/25 3:45 == 43.8	11/7/25 8:15 == 47.4	11/7/25 12:45 == 47.8
11/6/25 23:20 == 47.9	11/7/25 3:50 == 47.7	11/7/25 8:20 == 47.4	11/7/25 12:50 == 47.7
11/6/25 23:25 == 43.6	11/7/25 3:55 == 47.3	11/7/25 8:25 == 47.1	11/7/25 12:55 == 47.7
11/6/25 23:30 == 35.6	11/7/25 4:00 == 47.5	11/7/25 8:30 == 47.3	11/7/25 13:00 == 47.5
11/6/25 23:35 == 32.3	11/7/25 4:05 == 47.8	11/7/25 8:35 == 47.2	11/7/25 13:05 == 47.7
11/6/25 23:40 == 32.3	11/7/25 4:10 == 47.5	11/7/25 8:40 == 46.2	11/7/25 13:10 == 47.7
11/6/25 23:45 == 32.3	11/7/25 4:15 == 47.7	11/7/25 8:45 == 34.9	11/7/25 13:15 == 47.7
11/6/25 23:50 == 32.3	11/7/25 4:20 == 48	11/7/25 8:50 == 32.2	11/7/25 13:20 == 47.6
11/6/25 23:55 == 32.5	11/7/25 4:25 == 44.2	11/7/25 8:55 == 32.2	11/7/25 13:25 == 47.8
11/7/25 0:00 == 32.4	11/7/25 4:30 == 36.7	11/7/25 9:00 == 32.2	11/7/25 13:30 == 34.3
11/7/25 0:05 == 32.4	11/7/25 4:35 == 32.4	11/7/25 9:05 == 32.3	11/7/25 13:35 == 32.4
11/7/25 0:10 == 33.8	11/7/25 4:40 == 32.4	11/7/25 9:10 == 33.1	11/7/25 13:40 == 32.3
11/7/25 0:15 == 43.2	11/7/25 4:45 == 32.3	11/7/25 9:15 == 41.9	11/7/25 13:45 == 32.4
11/7/25 0:20 == 47.8	11/7/25 4:50 == 32.4	11/7/25 9:20 == 47.4	11/7/25 13:50 == 32.3
11/7/25 0:25 == 47.8	11/7/25 4:55 == 32.4	11/7/25 9:25 == 47.5	11/7/25 13:55 == 32.3
11/7/25 0:30 == 48.1	11/7/25 5:00 == 32.4	11/7/25 9:30 == 47.6	11/7/25 14:00 == 32.3
11/7/25 0:35 == 47.9	11/7/25 5:05 == 32.5	11/7/25 9:35 == 47.7	11/7/25 14:05 == 32.4
11/7/25 0:40 == 47.9	11/7/25 5:10 == 32.5	11/7/25 9:40 == 47.7	11/7/25 14:10 == 32.4
11/7/25 0:45 == 47.8	11/7/25 5:15 == 32.5	11/7/25 9:45 == 47.8	11/7/25 14:15 == 42.2
11/7/25 0:50 == 48	11/7/25 5:20 == 32.4	11/7/25 9:50 == 47.6	11/7/25 14:20 == 47.5
11/7/25 0:55 == 47.5	11/7/25 5:25 == 33.2	11/7/25 9:55 == 47.5	11/7/25 14:25 == 47.8
11/7/25 1:00 == 47.7	11/7/25 5:30 == 42.8	11/7/25 10:00 == 47.5	11/7/25 14:30 == 47.8
11/7/25 1:05 == 47.8	11/7/25 5:35 == 47.7	11/7/25 10:05 == 47.3	11/7/25 14:35 == 47.7
11/7/25 1:10 == 44.4	11/7/25 5:40 == 48	11/7/25 10:10 == 44.8	11/7/25 14:40 == 47.5
11/7/25 1:15 == 35.3	11/7/25 5:45 == 47.9	11/7/25 10:15 == 36.4	11/7/25 14:45 == 47.7
11/7/25 1:20 == 32.4	11/7/25 5:50 == 47.7	11/7/25 10:20 == 32.8	11/7/25 14:50 == 47.9
11/7/25 1:25 == 32.4	11/7/25 5:55 == 47.9	11/7/25 10:25 == 33	11/7/25 14:55 == 47.8
11/7/25 1:30 == 32.3	11/7/25 6:00 == 47.8	11/7/25 10:30 == 32.7	11/7/25 15:00 == 47.9
11/7/25 1:35 == 32.3	11/7/25 6:05 == 47.8	11/7/25 10:35 == 32.9	11/7/25 15:05 == 47.9
11/7/25 1:40 == 32.3	11/7/25 6:10 == 47.7	11/7/25 10:40 == 32.6	11/7/25 15:10 == 47.8
11/7/25 1:45 == 32.4	11/7/25 6:15 == 47.8	11/7/25 10:45 == 32.5	11/7/25 15:15 == 47.5
11/7/25 1:50 == 32.3	11/7/25 6:20 == 48	11/7/25 10:50 == 32.7	11/7/25 15:20 == 47.7
11/7/25 1:55 == 34.8	11/7/25 6:25 == 47.8	11/7/25 10:55 == 32.2	11/7/25 15:25 == 45.6
11/7/25 2:00 == 42	11/7/25 6:30 == 47.8	11/7/25 11:00 == 42.7	11/7/25 15:30 == 37.2
11/7/25 2:05 == 47.5	11/7/25 6:35 == 48	11/7/25 11:05 == 47	11/7/25 15:35 == 32.3
11/7/25 2:10 == 47.5	11/7/25 6:40 == 44.2	11/7/25 11:10 == 47.3	11/7/25 15:40 == 32.4
11/7/25 2:15 == 47.5	11/7/25 6:45 == 36.2	11/7/25 11:15 == 47.8	11/7/25 15:45 == 32.3
11/7/25 2:20 == 47.5	11/7/25 6:50 == 32.2	11/7/25 11:20 == 48	11/7/25 15:50 == 32.4
11/7/25 2:25 == 47.5	11/7/25 6:55 == 32.3	11/7/25 11:25 == 47.9	11/7/25 15:55 == 32.3
11/7/25 2:30 == 47.6	11/7/25 7:00 == 32.3	11/7/25 11:30 == 47.9	11/7/25 16:00 == 32.4
11/7/25 2:35 == 47.8	11/7/25 7:05 == 32.4	11/7/25 11:35 == 47.9	11/7/25 16:05 == 32.4
11/7/25 2:40 == 47.8	11/7/25 7:10 == 32.5	11/7/25 11:40 == 47.4	11/7/25 16:10 == 32.3
11/7/25 2:45 == 47.6	11/7/25 7:15 == 32.4	11/7/25 11:45 == 47.6	11/7/25 16:15 == 42
11/7/25 2:50 == 47.6	11/7/25 7:20 == 32.4	11/7/25 11:50 == 47.8	11/7/25 16:20 == 47.2
11/7/25 2:55 == 47.2	11/7/25 7:25 == 34.4	11/7/25 11:55 == 45.2	11/7/25 16:25 == 47.7
11/7/25 3:00 == 47.7	11/7/25 7:30 == 41.4	11/7/25 12:00 == 37.5	11/7/25 16:30 == 47.7
11/7/25 3:05 == 47.6	11/7/25 7:35 == 47.6	11/7/25 12:05 == 32.5	11/7/25 16:35 == 47.4
11/7/25 3:10 == 46.8	11/7/25 7:40 == 47.1	11/7/25 12:10 == 32.4	11/7/25 16:40 == 47.6
11/7/25 3:15 == 33.2	11/7/25 7:45 == 47.5	11/7/25 12:15 == 32.3	11/7/25 16:45 == 47.9
11/7/25 3:20 == 32.4	11/7/25 7:50 == 47.7	11/7/25 12:20 == 32.3	11/7/25 16:50 == 47.9
11/7/25 3:25 == 32.4	11/7/25 7:55 == 47.7	11/7/25 12:25 == 34.1	11/7/25 16:55 == 46

Pumpback Station Discharge (0364)

11/7/25 17:00 == 37.2	11/7/25 21:30 == 47.5	11/8/25 2:00 == 47.4	11/8/25 6:30 == 39.5
11/7/25 17:05 == 32.4	11/7/25 21:35 == 47.6	11/8/25 2:05 == 47.7	11/8/25 6:35 == 32.3
11/7/25 17:10 == 32.3	11/7/25 21:40 == 47.8	11/8/25 2:10 == 47.6	11/8/25 6:40 == 32.3
11/7/25 17:15 == 32.3	11/7/25 21:45 == 47.7	11/8/25 2:15 == 47.6	11/8/25 6:45 == 32.2
11/7/25 17:20 == 32.5	11/7/25 21:50 == 47.7	11/8/25 2:20 == 47.6	11/8/25 6:50 == 32.4
11/7/25 17:25 == 32.5	11/7/25 21:55 == 47.3	11/8/25 2:25 == 47.4	11/8/25 6:55 == 32.4
11/7/25 17:30 == 32.4	11/7/25 22:00 == 47.6	11/8/25 2:30 == 47.7	11/8/25 7:00 == 32.5
11/7/25 17:35 == 32.4	11/7/25 22:05 == 47.8	11/8/25 2:35 == 47.9	11/8/25 7:05 == 32.4
11/7/25 17:40 == 33.8	11/7/25 22:10 == 46.1	11/8/25 2:40 == 47.8	11/8/25 7:10 == 33.2
11/7/25 17:45 == 40	11/7/25 22:15 == 37.8	11/8/25 2:45 == 36.6	11/8/25 7:15 == 38.3
11/7/25 17:50 == 47.7	11/7/25 22:20 == 32.5	11/8/25 2:50 == 32.8	11/8/25 7:20 == 47.8
11/7/25 17:55 == 47.4	11/7/25 22:25 == 32.3	11/8/25 2:55 == 32.2	11/8/25 7:25 == 47.9
11/7/25 18:00 == 47.7	11/7/25 22:30 == 32.2	11/8/25 3:00 == 32.4	11/8/25 7:30 == 48
11/7/25 18:05 == 47.7	11/7/25 22:35 == 32.3	11/8/25 3:05 == 32.5	11/8/25 7:35 == 47.9
11/7/25 18:10 == 47.8	11/7/25 22:40 == 33.4	11/8/25 3:10 == 32.4	11/8/25 7:40 == 47.1
11/7/25 18:15 == 47.8	11/7/25 22:45 == 39.7	11/8/25 3:15 == 32.3	11/8/25 7:45 == 47.6
11/7/25 18:20 == 47.9	11/7/25 22:50 == 47.8	11/8/25 3:20 == 32.4	11/8/25 7:50 == 47.9
11/7/25 18:25 == 47.2	11/7/25 22:55 == 47.7	11/8/25 3:25 == 32.4	11/8/25 7:55 == 47.8
11/7/25 18:30 == 47.6	11/7/25 23:00 == 47.7	11/8/25 3:30 == 39.7	11/8/25 8:00 == 47.9
11/7/25 18:35 == 47.8	11/7/25 23:05 == 47.9	11/8/25 3:35 == 46.9	11/8/25 8:05 == 47.7
11/7/25 18:40 == 47.6	11/7/25 23:10 == 47.8	11/8/25 3:40 == 47.9	11/8/25 8:10 == 47.7
11/7/25 18:45 == 35.2	11/7/25 23:15 == 48	11/8/25 3:45 == 47.9	11/8/25 8:15 == 47.6
11/7/25 18:50 == 32.5	11/7/25 23:20 == 47.9	11/8/25 3:50 == 47.6	11/8/25 8:20 == 47.5
11/7/25 18:55 == 32.3	11/7/25 23:25 == 46.5	11/8/25 3:55 == 47.4	11/8/25 8:25 == 47.6
11/7/25 19:00 == 32.3	11/7/25 23:30 == 37.6	11/8/25 4:00 == 47.7	11/8/25 8:30 == 38.5
11/7/25 19:05 == 32.5	11/7/25 23:35 == 32.4	11/8/25 4:05 == 47.9	11/8/25 8:35 == 32.4
11/7/25 19:10 == 32.5	11/7/25 23:40 == 32.5	11/8/25 4:10 == 47.8	11/8/25 8:40 == 32.3
11/7/25 19:15 == 41.7	11/7/25 23:45 == 32.3	11/8/25 4:15 == 47.9	11/8/25 8:45 == 32.2
11/7/25 19:20 == 47.1	11/7/25 23:50 == 32.4	11/8/25 4:20 == 47.9	11/8/25 8:50 == 32.2
11/7/25 19:25 == 47.2	11/7/25 23:55 == 32.4	11/8/25 4:25 == 47.7	11/8/25 8:55 == 32.3
11/7/25 19:30 == 47.4	11/8/25 0:00 == 40.8	11/8/25 4:30 == 47.8	11/8/25 9:00 == 38.3
11/7/25 19:35 == 47.9	11/8/25 0:05 == 46.9	11/8/25 4:35 == 47.9	11/8/25 9:05 == 47.2
11/7/25 19:40 == 47.9	11/8/25 0:10 == 47.3	11/8/25 4:40 == 46.8	11/8/25 9:10 == 47.4
11/7/25 19:45 == 47.9	11/8/25 0:15 == 47.4	11/8/25 4:45 == 38.6	11/8/25 9:15 == 47.6
11/7/25 19:50 == 47.9	11/8/25 0:20 == 47.8	11/8/25 4:50 == 32.6	11/8/25 9:20 == 47.7
11/7/25 19:55 == 47.7	11/8/25 0:25 == 48	11/8/25 4:55 == 32.4	11/8/25 9:25 == 47.5
11/7/25 20:00 == 47.6	11/8/25 0:30 == 48	11/8/25 5:00 == 32.3	11/8/25 9:30 == 47.5
11/7/25 20:05 == 47.6	11/8/25 0:35 == 48	11/8/25 5:05 == 32.4	11/8/25 9:35 == 47.7
11/7/25 20:10 == 45.2	11/8/25 0:40 == 47.9	11/8/25 5:10 == 32.5	11/8/25 9:40 == 47.7
11/7/25 20:15 == 38.3	11/8/25 0:45 == 48	11/8/25 5:15 == 32.4	11/8/25 9:45 == 47.7
11/7/25 20:20 == 32.2	11/8/25 0:50 == 48	11/8/25 5:20 == 32.3	11/8/25 9:50 == 47.6
11/7/25 20:25 == 32.1	11/8/25 0:55 == 46.4	11/8/25 5:25 == 32.4	11/8/25 9:55 == 47.4
11/7/25 20:30 == 32.3	11/8/25 1:00 == 38.6	11/8/25 5:30 == 39.9	11/8/25 10:00 == 38.7
11/7/25 20:35 == 32.4	11/8/25 1:05 == 32.4	11/8/25 5:35 == 46	11/8/25 10:05 == 32.3
11/7/25 20:40 == 32.4	11/8/25 1:10 == 32.3	11/8/25 5:40 == 47.6	11/8/25 10:10 == 32.6
11/7/25 20:45 == 32.5	11/8/25 1:15 == 32.3	11/8/25 5:45 == 47.8	11/8/25 10:15 == 32.3
11/7/25 20:50 == 32.4	11/8/25 1:20 == 32.4	11/8/25 5:50 == 47.9	11/8/25 10:20 == 32.4
11/7/25 20:55 == 32.9	11/8/25 1:25 == 32.3	11/8/25 5:55 == 47.7	11/8/25 10:25 == 32.9
11/7/25 21:00 == 39.8	11/8/25 1:30 == 32.1	11/8/25 6:00 == 47.7	11/8/25 10:30 == 40
11/7/25 21:05 == 47.8	11/8/25 1:35 == 32.2	11/8/25 6:05 == 47.8	11/8/25 10:35 == 46.1
11/7/25 21:10 == 47.4	11/8/25 1:40 == 33.2	11/8/25 6:10 == 47.8	11/8/25 10:40 == 47.6
11/7/25 21:15 == 47.5	11/8/25 1:45 == 38.6	11/8/25 6:15 == 47.8	11/8/25 10:45 == 47.7
11/7/25 21:20 == 47.5	11/8/25 1:50 == 47.7	11/8/25 6:20 == 47.8	11/8/25 10:50 == 47.8
11/7/25 21:25 == 47.2	11/8/25 1:55 == 47.6	11/8/25 6:25 == 46.1	11/8/25 10:55 == 47.4

Pumpback Station Discharge (0364)

11/8/25 11:00 == 47.5	11/8/25 15:30 == 38.9	11/8/25 20:00 == 47.8	11/9/25 0:30 == 48
11/8/25 11:05 == 47.8	11/8/25 15:35 == 33.1	11/8/25 20:05 == 47.7	11/9/25 0:35 == 47.9
11/8/25 11:10 == 47	11/8/25 15:40 == 32.3	11/8/25 20:10 == 47.7	11/9/25 0:40 == 47.9
11/8/25 11:15 == 39	11/8/25 15:45 == 32.3	11/8/25 20:15 == 47.7	11/9/25 0:45 == 47.9
11/8/25 11:20 == 32.5	11/8/25 15:50 == 32.3	11/8/25 20:20 == 47.7	11/9/25 0:50 == 47.7
11/8/25 11:25 == 32.3	11/8/25 15:55 == 32.2	11/8/25 20:25 == 47.6	11/9/25 0:55 == 47.6
11/8/25 11:30 == 32.3	11/8/25 16:00 == 32.3	11/8/25 20:30 == 47.6	11/9/25 1:00 == 47.8
11/8/25 11:35 == 32.4	11/8/25 16:05 == 32.3	11/8/25 20:35 == 47.5	11/9/25 1:05 == 44.3
11/8/25 11:40 == 32.4	11/8/25 16:10 == 32.2	11/8/25 20:40 == 47.1	11/9/25 1:10 == 35.8
11/8/25 11:45 == 32.4	11/8/25 16:15 == 38.7	11/8/25 20:45 == 47.8	11/9/25 1:15 == 32.4
11/8/25 11:50 == 32.4	11/8/25 16:20 == 45.6	11/8/25 20:50 == 47.8	11/9/25 1:20 == 32.5
11/8/25 11:55 == 32.9	11/8/25 16:25 == 47.4	11/8/25 20:55 == 47.9	11/9/25 1:25 == 32.4
11/8/25 12:00 == 37.1	11/8/25 16:30 == 47.5	11/8/25 21:00 == 47.8	11/9/25 1:30 == 32.4
11/8/25 12:05 == 47.7	11/8/25 16:35 == 47.7	11/8/25 21:05 == 47.8	11/9/25 1:35 == 33.4
11/8/25 12:10 == 47.7	11/8/25 16:40 == 47.6	11/8/25 21:10 == 47.4	11/9/25 1:40 == 43
11/8/25 12:15 == 47.7	11/8/25 16:45 == 47.8	11/8/25 21:15 == 47.5	11/9/25 1:45 == 47.6
11/8/25 12:20 == 47.8	11/8/25 16:50 == 47.7	11/8/25 21:20 == 47.5	11/9/25 1:50 == 47.7
11/8/25 12:25 == 47.7	11/8/25 16:55 == 46.6	11/8/25 21:25 == 47.9	11/9/25 1:55 == 47.5
11/8/25 12:30 == 47.8	11/8/25 17:00 == 41.2	11/8/25 21:30 == 47.8	11/9/25 2:00 == 47.5
11/8/25 12:35 == 47.6	11/8/25 17:05 == 32.3	11/8/25 21:35 == 47.7	11/9/25 2:05 == 47.6
11/8/25 12:40 == 47.8	11/8/25 17:10 == 32.3	11/8/25 21:40 == 47.6	11/9/25 2:10 == 47.3
11/8/25 12:45 == 47.5	11/8/25 17:15 == 32.5	11/8/25 21:45 == 47.7	11/9/25 2:15 == 47.3
11/8/25 12:50 == 47.6	11/8/25 17:20 == 18.8	11/8/25 21:50 == 48	11/9/25 2:20 == 47.4
11/8/25 12:55 == 47.6	11/8/25 17:25 == 5.9	11/8/25 21:55 == 47.4	11/9/25 2:25 == 47.2
11/8/25 13:00 == 47.4	11/8/25 17:30 == 0	11/8/25 22:00 == 47.5	11/9/25 2:30 == 47.7
11/8/25 13:05 == 47.5	11/8/25 17:35 == 0	11/8/25 22:05 == 47.7	11/9/25 2:35 == 47.8
11/8/25 13:10 == 47.5	11/8/25 17:40 == 0	11/8/25 22:10 == 47.8	11/9/25 2:40 == 47.8
11/8/25 13:15 == 47.4	11/8/25 17:45 == 0	11/8/25 22:15 == 47.8	11/9/25 2:45 == 47.8
11/8/25 13:20 == 47.5	11/8/25 17:50 == 5.6	11/8/25 22:20 == 47.9	11/9/25 2:50 == 47.8
11/8/25 13:25 == 47.5	11/8/25 17:55 == 25	11/8/25 22:25 == 47.6	11/9/25 2:55 == 47.3
11/8/25 13:30 == 38.5	11/8/25 18:00 == 44.6	11/8/25 22:30 == 47.4	11/9/25 3:00 == 47.5
11/8/25 13:35 == 32.8	11/8/25 18:05 == 47.8	11/8/25 22:35 == 47.6	11/9/25 3:05 == 47.8
11/8/25 13:40 == 32.2	11/8/25 18:10 == 47.5	11/8/25 22:40 == 47.7	11/9/25 3:10 == 47.8
11/8/25 13:45 == 32.2	11/8/25 18:15 == 47.9	11/8/25 22:45 == 47.7	11/9/25 3:15 == 47.8
11/8/25 13:50 == 32.2	11/8/25 18:20 == 47.9	11/8/25 22:50 == 44.2	11/9/25 3:20 == 44.3
11/8/25 13:55 == 32.2	11/8/25 18:25 == 47.4	11/8/25 22:55 == 35.1	11/9/25 3:25 == 36.5
11/8/25 14:00 == 32.2	11/8/25 18:30 == 47.6	11/8/25 23:00 == 32.3	11/9/25 3:30 == 32.4
11/8/25 14:05 == 32.3	11/8/25 18:35 == 47.6	11/8/25 23:05 == 32.5	11/9/25 3:35 == 32.3
11/8/25 14:10 == 32.3	11/8/25 18:40 == 47.2	11/8/25 23:10 == 32.5	11/9/25 3:40 == 32.4
11/8/25 14:15 == 37.7	11/8/25 18:45 == 47.8	11/8/25 23:15 == 32.5	11/9/25 3:45 == 32.5
11/8/25 14:20 == 47.2	11/8/25 18:50 == 47.8	11/8/25 23:20 == 33.3	11/9/25 3:50 == 34.2
11/8/25 14:25 == 47.7	11/8/25 18:55 == 47.3	11/8/25 23:25 == 44.3	11/9/25 3:55 == 43.2
11/8/25 14:30 == 47.7	11/8/25 19:00 == 48	11/8/25 23:30 == 47.9	11/9/25 4:00 == 47.7
11/8/25 14:35 == 47.8	11/8/25 19:05 == 48	11/8/25 23:35 == 47.8	11/9/25 4:05 == 48
11/8/25 14:40 == 47.8	11/8/25 19:10 == 48	11/8/25 23:40 == 47.7	11/9/25 4:10 == 47.3
11/8/25 14:45 == 47.8	11/8/25 19:15 == 48	11/8/25 23:45 == 47.8	11/9/25 4:15 == 47.8
11/8/25 14:50 == 47.8	11/8/25 19:20 == 48	11/8/25 23:50 == 47.8	11/9/25 4:20 == 48
11/8/25 14:55 == 47.6	11/8/25 19:25 == 47.3	11/8/25 23:55 == 47.8	11/9/25 4:25 == 47.9
11/8/25 15:00 == 47.6	11/8/25 19:30 == 47.8	11/9/25 0:00 == 47.8	11/9/25 4:30 == 48
11/8/25 15:05 == 47.8	11/8/25 19:35 == 47.9	11/9/25 0:05 == 47.7	11/9/25 4:35 == 47.9
11/8/25 15:10 == 47.8	11/8/25 19:40 == 47.9	11/9/25 0:10 == 47.2	11/9/25 4:40 == 47.8
11/8/25 15:15 == 47.5	11/8/25 19:45 == 48	11/9/25 0:15 == 47.6	11/9/25 4:45 == 47.9
11/8/25 15:20 == 47.8	11/8/25 19:50 == 48	11/9/25 0:20 == 47.8	11/9/25 4:50 == 47.9
11/8/25 15:25 == 47.6	11/8/25 19:55 == 47.9	11/9/25 0:25 == 47.9	11/9/25 4:55 == 47.7

Pumpback Station Discharge (0364)

11/9/25 5:00 == 47.8	11/9/25 9:30 == 32.1	11/9/25 14:00 == 47.6	11/9/25 18:30 == 46.7
11/9/25 5:05 == 48	11/9/25 9:35 == 33	11/9/25 14:05 == 46.4	11/9/25 18:35 == 47.6
11/9/25 5:10 == 47.6	11/9/25 9:40 == 42.4	11/9/25 14:10 == 36.1	11/9/25 18:40 == 47.4
11/9/25 5:15 == 47.6	11/9/25 9:45 == 47.4	11/9/25 14:15 == 32.4	11/9/25 18:45 == 47.3
11/9/25 5:20 == 47.9	11/9/25 9:50 == 47.9	11/9/25 14:20 == 32.3	11/9/25 18:50 == 47.6
11/9/25 5:25 == 47.8	11/9/25 9:55 == 47.7	11/9/25 14:25 == 32.4	11/9/25 18:55 == 47.8
11/9/25 5:30 == 47.8	11/9/25 10:00 == 47.7	11/9/25 14:30 == 32.4	11/9/25 19:00 == 48
11/9/25 5:35 == 44.1	11/9/25 10:05 == 47.6	11/9/25 14:35 == 33.4	11/9/25 19:05 == 48
11/9/25 5:40 == 36.5	11/9/25 10:10 == 47.4	11/9/25 14:40 == 40.9	11/9/25 19:10 == 47.9
11/9/25 5:45 == 32.5	11/9/25 10:15 == 47.7	11/9/25 14:45 == 47.5	11/9/25 19:15 == 47.9
11/9/25 5:50 == 32.5	11/9/25 10:20 == 47.9	11/9/25 14:50 == 47.8	11/9/25 19:20 == 47.8
11/9/25 5:55 == 32.3	11/9/25 10:25 == 47.7	11/9/25 14:55 == 47.9	11/9/25 19:25 == 47.6
11/9/25 6:00 == 32.5	11/9/25 10:30 == 47.7	11/9/25 15:00 == 47.7	11/9/25 19:30 == 47.6
11/9/25 6:05 == 34	11/9/25 10:35 == 48	11/9/25 15:05 == 47.7	11/9/25 19:35 == 47.9
11/9/25 6:10 == 41.8	11/9/25 10:40 == 47.9	11/9/25 15:10 == 47.4	11/9/25 19:40 == 47.9
11/9/25 6:15 == 47.3	11/9/25 10:45 == 47.8	11/9/25 15:15 == 47.3	11/9/25 19:45 == 48
11/9/25 6:20 == 47.8	11/9/25 10:50 == 45.9	11/9/25 15:20 == 47.7	11/9/25 19:50 == 45.8
11/9/25 6:25 == 47.9	11/9/25 10:55 == 35.3	11/9/25 15:25 == 47.8	11/9/25 19:55 == 37.7
11/9/25 6:30 == 47.9	11/9/25 11:00 == 32.2	11/9/25 15:30 == 47.8	11/9/25 20:00 == 32.4
11/9/25 6:35 == 47.8	11/9/25 11:05 == 32.4	11/9/25 15:35 == 46.7	11/9/25 20:05 == 32.4
11/9/25 6:40 == 47.6	11/9/25 11:10 == 32.5	11/9/25 15:40 == 35.7	11/9/25 20:10 == 32.4
11/9/25 6:45 == 47.5	11/9/25 11:15 == 32.2	11/9/25 15:45 == 32.4	11/9/25 20:15 == 32.4
11/9/25 6:50 == 47.4	11/9/25 11:20 == 32.4	11/9/25 15:50 == 32.4	11/9/25 20:20 == 32.7
11/9/25 6:55 == 47.6	11/9/25 11:25 == 43.2	11/9/25 15:55 == 32.4	11/9/25 20:25 == 40.7
11/9/25 7:00 == 47.6	11/9/25 11:30 == 47.4	11/9/25 16:00 == 32.5	11/9/25 20:30 == 47.2
11/9/25 7:05 == 47.7	11/9/25 11:35 == 48	11/9/25 16:05 == 32.4	11/9/25 20:35 == 47.6
11/9/25 7:10 == 47.2	11/9/25 11:40 == 47.4	11/9/25 16:10 == 32.3	11/9/25 20:40 == 47.2
11/9/25 7:15 == 47.5	11/9/25 11:45 == 47.7	11/9/25 16:15 == 32.4	11/9/25 20:45 == 47.7
11/9/25 7:20 == 47.8	11/9/25 11:50 == 47.9	11/9/25 16:20 == 32.4	11/9/25 20:50 == 47.4
11/9/25 7:25 == 47.9	11/9/25 11:55 == 47.8	11/9/25 16:25 == 42.1	11/9/25 20:55 == 47.8
11/9/25 7:30 == 47.9	11/9/25 12:00 == 47.9	11/9/25 16:30 == 47	11/9/25 21:00 == 47.8
11/9/25 7:35 == 44.6	11/9/25 12:05 == 48	11/9/25 16:35 == 47.8	11/9/25 21:05 == 47.8
11/9/25 7:40 == 36.9	11/9/25 12:10 == 47.8	11/9/25 16:40 == 47.7	11/9/25 21:10 == 47.7
11/9/25 7:45 == 32.3	11/9/25 12:15 == 47.7	11/9/25 16:45 == 47.7	11/9/25 21:15 == 47.7
11/9/25 7:50 == 32.4	11/9/25 12:20 == 44.8	11/9/25 16:50 == 47.8	11/9/25 21:20 == 47.7
11/9/25 7:55 == 32.4	11/9/25 12:25 == 37.4	11/9/25 16:55 == 47.8	11/9/25 21:25 == 47.5
11/9/25 8:00 == 32.4	11/9/25 12:30 == 32.3	11/9/25 17:00 == 47.8	11/9/25 21:30 == 47.5
11/9/25 8:05 == 34.4	11/9/25 12:35 == 32.3	11/9/25 17:05 == 47.8	11/9/25 21:35 == 45.6
11/9/25 8:10 == 41	11/9/25 12:40 == 32.3	11/9/25 17:10 == 47.7	11/9/25 21:40 == 38.2
11/9/25 8:15 == 47.6	11/9/25 12:45 == 32.4	11/9/25 17:15 == 47.6	11/9/25 21:45 == 32.3
11/9/25 8:20 == 47.5	11/9/25 12:50 == 33.9	11/9/25 17:20 == 47.8	11/9/25 21:50 == 32.6
11/9/25 8:25 == 47.5	11/9/25 12:55 == 40.5	11/9/25 17:25 == 47.9	11/9/25 21:55 == 32.7
11/9/25 8:30 == 47.7	11/9/25 13:00 == 47.4	11/9/25 17:30 == 47.8	11/9/25 22:00 == 32.4
11/9/25 8:35 == 47.6	11/9/25 13:05 == 47.5	11/9/25 17:35 == 45.7	11/9/25 22:05 == 33.7
11/9/25 8:40 == 47.6	11/9/25 13:10 == 47.6	11/9/25 17:40 == 37.6	11/9/25 22:10 == 39.2
11/9/25 8:45 == 47.5	11/9/25 13:15 == 47.6	11/9/25 17:45 == 32.6	11/9/25 22:15 == 47.6
11/9/25 8:50 == 47.5	11/9/25 13:20 == 47.5	11/9/25 17:50 == 32.4	11/9/25 22:20 == 48
11/9/25 8:55 == 47.6	11/9/25 13:25 == 47.8	11/9/25 17:55 == 32.5	11/9/25 22:25 == 47.5
11/9/25 9:00 == 47.7	11/9/25 13:30 == 47.7	11/9/25 18:00 == 32.5	11/9/25 22:30 == 47.6
11/9/25 9:05 == 47.2	11/9/25 13:35 == 47.7	11/9/25 18:05 == 32.5	11/9/25 22:35 == 47.8
11/9/25 9:10 == 34	11/9/25 13:40 == 47.8	11/9/25 18:10 == 32.4	11/9/25 22:40 == 47.9
11/9/25 9:15 == 32.4	11/9/25 13:45 == 47.6	11/9/25 18:15 == 32.4	11/9/25 22:45 == 47.8
11/9/25 9:20 == 32.3	11/9/25 13:50 == 47.6	11/9/25 18:20 == 32.5	11/9/25 22:50 == 47.7
11/9/25 9:25 == 32.3	11/9/25 13:55 == 47.5	11/9/25 18:25 == 41	11/9/25 22:55 == 47.9

Pumpback Station Discharge (0364)

11/9/25 23:00 == 47.9	11/10/25 3:30 == 32.5	11/10/25 8:00 == 47.9	11/10/25 12:30 == 47.9
11/9/25 23:05 == 47.8	11/10/25 3:35 == 32.5	11/10/25 8:05 == 48	11/10/25 12:35 == 47.9
11/9/25 23:10 == 47.4	11/10/25 3:40 == 32.4	11/10/25 8:10 == 47.8	11/10/25 12:40 == 47.8
11/9/25 23:15 == 47.8	11/10/25 3:45 == 32.5	11/10/25 8:15 == 47.8	11/10/25 12:45 == 47.7
11/9/25 23:20 == 47.9	11/10/25 3:50 == 32.4	11/10/25 8:20 == 47.7	11/10/25 12:50 == 47.7
11/9/25 23:25 == 36.6	11/10/25 3:55 == 40.4	11/10/25 8:25 == 47.7	11/10/25 12:55 == 47.6
11/9/25 23:30 == 32.5	11/10/25 4:00 == 46.5	11/10/25 8:30 == 47.7	11/10/25 13:00 == 47.7
11/9/25 23:35 == 32.5	11/10/25 4:05 == 47.9	11/10/25 8:35 == 47.7	11/10/25 13:05 == 47.6
11/9/25 23:40 == 32.4	11/10/25 4:10 == 47.5	11/10/25 8:40 == 47.5	11/10/25 13:10 == 47.6
11/9/25 23:45 == 32.4	11/10/25 4:15 == 47.5	11/10/25 8:45 == 47.6	11/10/25 13:15 == 47.6
11/9/25 23:50 == 32.4	11/10/25 4:20 == 47.6	11/10/25 8:50 == 47.6	11/10/25 13:20 == 47.8
11/9/25 23:55 == 40	11/10/25 4:25 == 47.8	11/10/25 8:55 == 47.3	11/10/25 13:25 == 47.7
11/10/25 0:00 == 47.6	11/10/25 4:30 == 47.8	11/10/25 9:00 == 47.4	11/10/25 13:30 == 47.8
11/10/25 0:05 == 47.8	11/10/25 4:35 == 47.9	11/10/25 9:05 == 47	11/10/25 13:35 == 47.8
11/10/25 0:10 == 47.6	11/10/25 4:40 == 47.9	11/10/25 9:10 == 39	11/10/25 13:40 == 47.7
11/10/25 0:15 == 47.7	11/10/25 4:45 == 47.9	11/10/25 9:15 == 32.5	11/10/25 13:45 == 47.6
11/10/25 0:20 == 47.8	11/10/25 4:50 == 47.9	11/10/25 9:20 == 32.4	11/10/25 13:50 == 47
11/10/25 0:25 == 47.9	11/10/25 4:55 == 47.9	11/10/25 9:25 == 32.3	11/10/25 13:55 == 39.7
11/10/25 0:30 == 48	11/10/25 5:00 == 47.9	11/10/25 9:30 == 32.4	11/10/25 14:00 == 32.4
11/10/25 0:35 == 47.9	11/10/25 5:05 == 47.9	11/10/25 9:35 == 32.8	11/10/25 14:05 == 32.4
11/10/25 0:40 == 47.9	11/10/25 5:10 == 47.8	11/10/25 9:40 == 37.8	11/10/25 14:10 == 32.4
11/10/25 0:45 == 47.9	11/10/25 5:15 == 47.9	11/10/25 9:45 == 47.6	11/10/25 14:15 == 32.5
11/10/25 0:50 == 48	11/10/25 5:20 == 46.3	11/10/25 9:50 == 47.8	11/10/25 14:20 == 32.9
11/10/25 0:55 == 47.8	11/10/25 5:25 == 39.1	11/10/25 9:55 == 47.7	11/10/25 14:25 == 37.4
11/10/25 1:00 == 47.8	11/10/25 5:30 == 32.5	11/10/25 10:00 == 47.9	11/10/25 14:30 == 47.6
11/10/25 1:05 == 47.8	11/10/25 5:35 == 32.4	11/10/25 10:05 == 47.6	11/10/25 14:35 == 47.9
11/10/25 1:10 == 37	11/10/25 5:40 == 32.5	11/10/25 10:10 == 46.9	11/10/25 14:40 == 47.7
11/10/25 1:15 == 32.6	11/10/25 5:45 == 32.5	11/10/25 10:15 == 47.8	11/10/25 14:45 == 47.7
11/10/25 1:20 == 32.5	11/10/25 5:50 == 32.5	11/10/25 10:20 == 47.9	11/10/25 14:50 == 48
11/10/25 1:25 == 32.5	11/10/25 5:55 == 39.3	11/10/25 10:25 == 47	11/10/25 14:55 == 47.8
11/10/25 1:30 == 32.3	11/10/25 6:00 == 46.7	11/10/25 10:30 == 47.7	11/10/25 15:00 == 47.8
11/10/25 1:35 == 32.3	11/10/25 6:05 == 47.7	11/10/25 10:35 == 47.8	11/10/25 15:05 == 47.8
11/10/25 1:40 == 40.3	11/10/25 6:10 == 48	11/10/25 10:40 == 48.1	11/10/25 15:10 == 47.4
11/10/25 1:45 == 46.4	11/10/25 6:15 == 47.8	11/10/25 10:45 == 48	11/10/25 15:15 == 47.6
11/10/25 1:50 == 47.8	11/10/25 6:20 == 47.9	11/10/25 10:50 == 48	11/10/25 15:20 == 47.8
11/10/25 1:55 == 47.8	11/10/25 6:25 == 47.9	11/10/25 10:55 == 47.4	11/10/25 15:25 == 47.8
11/10/25 2:00 == 47.7	11/10/25 6:30 == 48	11/10/25 11:00 == 47.4	11/10/25 15:30 == 48
11/10/25 2:05 == 47.8	11/10/25 6:35 == 47.9	11/10/25 11:05 == 47.8	11/10/25 15:35 == 47.9
11/10/25 2:10 == 47.7	11/10/25 6:40 == 47.7	11/10/25 11:10 == 47.5	11/10/25 15:40 == 47.5
11/10/25 2:15 == 47.6	11/10/25 6:45 == 47.8	11/10/25 11:15 == 47.8	11/10/25 15:45 == 47.7
11/10/25 2:20 == 47.7	11/10/25 6:50 == 47.8	11/10/25 11:20 == 48	11/10/25 15:50 == 47.9
11/10/25 2:25 == 47.5	11/10/25 6:55 == 47.7	11/10/25 11:25 == 39.3	11/10/25 15:55 == 39.3
11/10/25 2:30 == 47.5	11/10/25 7:00 == 47.7	11/10/25 11:30 == 32.6	11/10/25 16:00 == 33.1
11/10/25 2:35 == 47.9	11/10/25 7:05 == 46.4	11/10/25 11:35 == 32.6	11/10/25 16:05 == 32.4
11/10/25 2:40 == 47.8	11/10/25 7:10 == 39.8	11/10/25 11:40 == 32.5	11/10/25 16:10 == 32.4
11/10/25 2:45 == 47.9	11/10/25 7:15 == 32.3	11/10/25 11:45 == 32.5	11/10/25 16:15 == 32.3
11/10/25 2:50 == 47.7	11/10/25 7:20 == 32.3	11/10/25 11:50 == 32.7	11/10/25 16:20 == 32.4
11/10/25 2:55 == 47.3	11/10/25 7:25 == 32.4	11/10/25 11:55 == 37.7	11/10/25 16:25 == 32.4
11/10/25 3:00 == 47.8	11/10/25 7:30 == 32.5	11/10/25 12:00 == 47	11/10/25 16:30 == 32.5
11/10/25 3:05 == 46.4	11/10/25 7:35 == 33.2	11/10/25 12:05 == 47.9	11/10/25 16:35 == 32.7
11/10/25 3:10 == 38.4	11/10/25 7:40 == 37.5	11/10/25 12:10 == 47.9	11/10/25 16:40 == 37
11/10/25 3:15 == 32.4	11/10/25 7:45 == 47.8	11/10/25 12:15 == 48	11/10/25 16:45 == 47.4
11/10/25 3:20 == 32.4	11/10/25 7:50 == 47.9	11/10/25 12:20 == 47.8	11/10/25 16:50 == 47.8
11/10/25 3:25 == 32.5	11/10/25 7:55 == 48	11/10/25 12:25 == 47.9	11/10/25 16:55 == 47.9

Pumpback Station Discharge (0364)

11/10/25 17:00 == 47.7	11/10/25 21:30 == 32.5	11/11/25 2:00 == 47.9	11/11/25 6:30 == 48
11/10/25 17:05 == 47.9	11/10/25 21:35 == 32.6	11/11/25 2:05 == 47.8	11/11/25 6:35 == 47.9
11/10/25 17:10 == 47.6	11/10/25 21:40 == 35.4	11/11/25 2:10 == 47.8	11/11/25 6:40 == 47.6
11/10/25 17:15 == 47.9	11/10/25 21:45 == 47.3	11/11/25 2:15 == 47.9	11/11/25 6:45 == 47.9
11/10/25 17:20 == 47.8	11/10/25 21:50 == 47.8	11/11/25 2:20 == 47.3	11/11/25 6:50 == 48
11/10/25 17:25 == 47.3	11/10/25 21:55 == 47.3	11/11/25 2:25 == 42.2	11/11/25 6:55 == 47.7
11/10/25 17:30 == 47.9	11/10/25 22:00 == 47.8	11/11/25 2:30 == 32.3	11/11/25 7:00 == 47.8
11/10/25 17:35 == 47.9	11/10/25 22:05 == 48.1	11/11/25 2:35 == 32.4	11/11/25 7:05 == 47.8
11/10/25 17:40 == 47.9	11/10/25 22:10 == 48	11/11/25 2:40 == 32.5	11/11/25 7:10 == 47.3
11/10/25 17:45 == 47.8	11/10/25 22:15 == 47.8	11/11/25 2:45 == 32.5	11/11/25 7:15 == 47.9
11/10/25 17:50 == 47.7	11/10/25 22:20 == 48	11/11/25 2:50 == 32.6	11/11/25 7:20 == 47.8
11/10/25 17:55 == 47.4	11/10/25 22:25 == 47.7	11/11/25 2:55 == 36.2	11/11/25 7:25 == 47.9
11/10/25 18:00 == 47.6	11/10/25 22:30 == 47.8	11/11/25 3:00 == 45.8	11/11/25 7:30 == 47.8
11/10/25 18:05 == 47.9	11/10/25 22:35 == 47.9	11/11/25 3:05 == 47.6	11/11/25 7:35 == 47.8
11/10/25 18:10 == 47.8	11/10/25 22:40 == 47.9	11/11/25 3:10 == 47.8	11/11/25 7:40 == 47
11/10/25 18:15 == 47.9	11/10/25 22:45 == 47.8	11/11/25 3:15 == 47.9	11/11/25 7:45 == 47.4
11/10/25 18:20 == 47.9	11/10/25 22:50 == 47.9	11/11/25 3:20 == 47.9	11/11/25 7:50 == 47.7
11/10/25 18:25 == 47.5	11/10/25 22:55 == 47.9	11/11/25 3:25 == 47.5	11/11/25 7:55 == 47.8
11/10/25 18:30 == 47.4	11/10/25 23:00 == 47.7	11/11/25 3:30 == 47.7	11/11/25 8:00 == 47.9
11/10/25 18:35 == 46.9	11/10/25 23:05 == 47.8	11/11/25 3:35 == 47.9	11/11/25 8:05 == 47.9
11/10/25 18:40 == 40.3	11/10/25 23:10 == 47.6	11/11/25 3:40 == 47.8	11/11/25 8:10 == 47.8
11/10/25 18:45 == 32.5	11/10/25 23:15 == 47.6	11/11/25 3:45 == 47.9	11/11/25 8:15 == 47.8
11/10/25 18:50 == 32.5	11/10/25 23:20 == 47.9	11/11/25 3:50 == 47.9	11/11/25 8:20 == 47.6
11/10/25 18:55 == 32.6	11/10/25 23:25 == 47.8	11/11/25 3:55 == 47.6	11/11/25 8:25 == 47.7
11/10/25 19:00 == 32.5	11/10/25 23:30 == 47.7	11/11/25 4:00 == 47.6	11/11/25 8:30 == 47.8
11/10/25 19:05 == 32.7	11/10/25 23:35 == 47.6	11/11/25 4:05 == 47.8	11/11/25 8:35 == 47.7
11/10/25 19:10 == 36.6	11/10/25 23:40 == 47.7	11/11/25 4:10 == 47.8	11/11/25 8:40 == 42.6
11/10/25 19:15 == 47.5	11/10/25 23:45 == 47.9	11/11/25 4:15 == 47.9	11/11/25 8:45 == 33.1
11/10/25 19:20 == 47.9	11/10/25 23:50 == 47.3	11/11/25 4:20 == 48	11/11/25 8:50 == 32.3
11/10/25 19:25 == 47.2	11/10/25 23:55 == 42.7	11/11/25 4:25 == 48	11/11/25 8:55 == 32.3
11/10/25 19:30 == 47.8	11/11/25 0:00 == 32.3	11/11/25 4:30 == 48	11/11/25 9:00 == 32.3
11/10/25 19:35 == 47.9	11/11/25 0:05 == 32.4	11/11/25 4:35 == 48	11/11/25 9:05 == 32.5
11/10/25 19:40 == 47.9	11/11/25 0:10 == 32.7	11/11/25 4:40 == 47.8	11/11/25 9:10 == 34.3
11/10/25 19:45 == 47.9	11/11/25 0:15 == 32.6	11/11/25 4:45 == 47.9	11/11/25 9:15 == 46.9
11/10/25 19:50 == 48	11/11/25 0:20 == 32.5	11/11/25 4:50 == 47.9	11/11/25 9:20 == 47.9
11/10/25 19:55 == 47.9	11/11/25 0:25 == 36.3	11/11/25 4:55 == 47.8	11/11/25 9:25 == 47.8
11/10/25 20:00 == 47.7	11/11/25 0:30 == 46.6	11/11/25 5:00 == 47.9	11/11/25 9:30 == 47.7
11/10/25 20:05 == 47.8	11/11/25 0:35 == 47.7	11/11/25 5:05 == 47.7	11/11/25 9:35 == 47.9
11/10/25 20:10 == 47.8	11/11/25 0:40 == 48	11/11/25 5:10 == 41.1	11/11/25 9:40 == 47.9
11/10/25 20:15 == 47.7	11/11/25 0:45 == 48	11/11/25 5:15 == 33.5	11/11/25 9:45 == 47.7
11/10/25 20:20 == 47.8	11/11/25 0:50 == 48.1	11/11/25 5:20 == 32.3	11/11/25 9:50 == 47.8
11/10/25 20:25 == 47.8	11/11/25 0:55 == 47.8	11/11/25 5:25 == 32.4	11/11/25 9:55 == 47.7
11/10/25 20:30 == 47.7	11/11/25 1:00 == 47.8	11/11/25 5:30 == 32.5	11/11/25 10:00 == 47.7
11/10/25 20:35 == 47.7	11/11/25 1:05 == 47.9	11/11/25 5:35 == 32.4	11/11/25 10:05 == 47.9
11/10/25 20:40 == 47.2	11/11/25 1:10 == 47.9	11/11/25 5:40 == 37.4	11/11/25 10:10 == 47.1
11/10/25 20:45 == 47.3	11/11/25 1:15 == 47.9	11/11/25 5:45 == 44.8	11/11/25 10:15 == 47.5
11/10/25 20:50 == 47.5	11/11/25 1:20 == 47.9	11/11/25 5:50 == 47.9	11/11/25 10:20 == 48
11/10/25 20:55 == 47.5	11/11/25 1:25 == 47.8	11/11/25 5:55 == 47.9	11/11/25 10:25 == 47.3
11/10/25 21:00 == 47.8	11/11/25 1:30 == 47.8	11/11/25 6:00 == 47.9	11/11/25 10:30 == 47.4
11/10/25 21:05 == 47.1	11/11/25 1:35 == 47.8	11/11/25 6:05 == 47.9	11/11/25 10:35 == 47.9
11/10/25 21:10 == 41.5	11/11/25 1:40 == 47.9	11/11/25 6:10 == 47.8	11/11/25 10:40 == 48
11/10/25 21:15 == 32.3	11/11/25 1:45 == 47.8	11/11/25 6:15 == 47.6	11/11/25 10:45 == 48
11/10/25 21:20 == 32.3	11/11/25 1:50 == 47.7	11/11/25 6:20 == 47.6	11/11/25 10:50 == 47.7
11/10/25 21:25 == 32.5	11/11/25 1:55 == 47.8	11/11/25 6:25 == 48	11/11/25 10:55 == 47.5

Pumpback Station Discharge (0364)

11/11/25 11:00 == 47.7	11/11/25 15:30 == 32.3	11/11/25 20:00 == 47.6	11/12/25 0:30 == 47.8
11/11/25 11:05 == 47.6	11/11/25 15:35 == 32.3	11/11/25 20:05 == 47.6	11/12/25 0:35 == 47.7
11/11/25 11:10 == 47.5	11/11/25 15:40 == 35.8	11/11/25 20:10 == 47.6	11/12/25 0:40 == 43.3
11/11/25 11:15 == 47.7	11/11/25 15:45 == 43.8	11/11/25 20:15 == 47.6	11/12/25 0:45 == 35.9
11/11/25 11:20 == 47.9	11/11/25 15:50 == 47.6	11/11/25 20:20 == 47.7	11/12/25 0:50 == 32.3
11/11/25 11:25 == 47.9	11/11/25 15:55 == 47.7	11/11/25 20:25 == 47.5	11/12/25 0:55 == 32.2
11/11/25 11:30 == 47.8	11/11/25 16:00 == 47.7	11/11/25 20:30 == 47.6	11/12/25 1:00 == 32.4
11/11/25 11:35 == 47.9	11/11/25 16:05 == 47.7	11/11/25 20:35 == 47.5	11/12/25 1:05 == 32.4
11/11/25 11:40 == 47.3	11/11/25 16:10 == 47.7	11/11/25 20:40 == 47.2	11/12/25 1:10 == 34.7
11/11/25 11:45 == 47.8	11/11/25 16:15 == 47.7	11/11/25 20:45 == 47.8	11/12/25 1:15 == 42.9
11/11/25 11:50 == 48	11/11/25 16:20 == 47.8	11/11/25 20:50 == 47.9	11/12/25 1:20 == 47.7
11/11/25 11:55 == 48	11/11/25 16:25 == 47.7	11/11/25 20:55 == 47.8	11/12/25 1:25 == 47.8
11/11/25 12:00 == 47.8	11/11/25 16:30 == 47.9	11/11/25 21:00 == 47.6	11/12/25 1:30 == 47.5
11/11/25 12:05 == 47.8	11/11/25 16:35 == 47.6	11/11/25 21:05 == 47.8	11/12/25 1:35 == 47.6
11/11/25 12:10 == 42.8	11/11/25 16:40 == 47.6	11/11/25 21:10 == 47.4	11/12/25 1:40 == 47.8
11/11/25 12:15 == 33.9	11/11/25 16:45 == 47.9	11/11/25 21:15 == 47.5	11/12/25 1:45 == 47.6
11/11/25 12:20 == 32.3	11/11/25 16:50 == 47.6	11/11/25 21:20 == 47.6	11/12/25 1:50 == 47.6
11/11/25 12:25 == 32.3	11/11/25 16:55 == 47.7	11/11/25 21:25 == 47.3	11/12/25 1:55 == 47.4
11/11/25 12:30 == 32.4	11/11/25 17:00 == 47.8	11/11/25 21:30 == 47.5	11/12/25 2:00 == 47.4
11/11/25 12:35 == 32.4	11/11/25 17:05 == 47.8	11/11/25 21:35 == 47.7	11/12/25 2:05 == 47.3
11/11/25 12:40 == 35.9	11/11/25 17:10 == 47.3	11/11/25 21:40 == 47.6	11/12/25 2:10 == 47.6
11/11/25 12:45 == 43.7	11/11/25 17:15 == 47.6	11/11/25 21:45 == 47.6	11/12/25 2:15 == 47.3
11/11/25 12:50 == 47.5	11/11/25 17:20 == 47.9	11/11/25 21:50 == 47.8	11/12/25 2:20 == 47.5
11/11/25 12:55 == 47.5	11/11/25 17:25 == 47.8	11/11/25 21:55 == 47.3	11/12/25 2:25 == 47.3
11/11/25 13:00 == 47.5	11/11/25 17:30 == 47.8	11/11/25 22:00 == 47.5	11/12/25 2:30 == 47.6
11/11/25 13:05 == 47.5	11/11/25 17:35 == 48	11/11/25 22:05 == 47.9	11/12/25 2:35 == 47.8
11/11/25 13:10 == 47.4	11/11/25 17:40 == 47.9	11/11/25 22:10 == 47.9	11/12/25 2:40 == 47.8
11/11/25 13:15 == 47.5	11/11/25 17:45 == 47.9	11/11/25 22:15 == 47.9	11/12/25 2:45 == 47.8
11/11/25 13:20 == 47.5	11/11/25 17:50 == 47.9	11/11/25 22:20 == 47.7	11/12/25 2:50 == 47.9
11/11/25 13:25 == 47.5	11/11/25 17:55 == 47.7	11/11/25 22:25 == 47.3	11/12/25 2:55 == 47.5
11/11/25 13:30 == 47.6	11/11/25 18:00 == 47.6	11/11/25 22:30 == 47.2	11/12/25 3:00 == 47.4
11/11/25 13:35 == 47.5	11/11/25 18:05 == 47.8	11/11/25 22:35 == 47.5	11/12/25 3:05 == 47.7
11/11/25 13:40 == 47.5	11/11/25 18:10 == 47.9	11/11/25 22:40 == 47.5	11/12/25 3:10 == 47.6
11/11/25 13:45 == 47.3	11/11/25 18:15 == 47.7	11/11/25 22:45 == 47.6	11/12/25 3:15 == 47.7
11/11/25 13:50 == 47.4	11/11/25 18:20 == 47.6	11/11/25 22:50 == 47.6	11/12/25 3:20 == 47.6
11/11/25 13:55 == 47.7	11/11/25 18:25 == 47	11/11/25 22:55 == 47.6	11/12/25 3:25 == 47.4
11/11/25 14:00 == 47.4	11/11/25 18:30 == 47.1	11/11/25 23:00 == 47.7	11/12/25 3:30 == 47.6
11/11/25 14:05 == 47.6	11/11/25 18:35 == 47.6	11/11/25 23:05 == 47.7	11/12/25 3:35 == 47.7
11/11/25 14:10 == 47.7	11/11/25 18:40 == 47.4	11/11/25 23:10 == 47.2	11/12/25 3:40 == 47.6
11/11/25 14:15 == 47.8	11/11/25 18:45 == 47.6	11/11/25 23:15 == 47.8	11/12/25 3:45 == 47.7
11/11/25 14:20 == 47.7	11/11/25 18:50 == 47.5	11/11/25 23:20 == 48	11/12/25 3:50 == 47.5
11/11/25 14:25 == 47.9	11/11/25 18:55 == 45.2	11/11/25 23:25 == 47.6	11/12/25 3:55 == 47.1
11/11/25 14:30 == 47.8	11/11/25 19:00 == 33	11/11/25 23:30 == 47.6	11/12/25 4:00 == 47.7
11/11/25 14:35 == 47.7	11/11/25 19:05 == 32.4	11/11/25 23:35 == 47.7	11/12/25 4:05 == 47.8
11/11/25 14:40 == 47.5	11/11/25 19:10 == 32.3	11/11/25 23:40 == 47.7	11/12/25 4:10 == 47.8
11/11/25 14:45 == 47.7	11/11/25 19:15 == 32.3	11/11/25 23:45 == 47.8	11/12/25 4:15 == 47.7
11/11/25 14:50 == 47.7	11/11/25 19:20 == 32.3	11/11/25 23:50 == 47.7	11/12/25 4:20 == 47.9
11/11/25 14:55 == 47.6	11/11/25 19:25 == 34.4	11/11/25 23:55 == 47.7	11/12/25 4:25 == 47.9
11/11/25 15:00 == 47.7	11/11/25 19:30 == 43.8	11/12/25 0:00 == 47.8	11/12/25 4:30 == 48
11/11/25 15:05 == 47.9	11/11/25 19:35 == 47.6	11/12/25 0:05 == 47.8	11/12/25 4:35 == 47.7
11/11/25 15:10 == 41.9	11/11/25 19:40 == 47.7	11/12/25 0:10 == 47.4	11/12/25 4:40 == 47.7
11/11/25 15:15 == 34.7	11/11/25 19:45 == 47.8	11/12/25 0:15 == 47.7	11/12/25 4:45 == 47.7
11/11/25 15:20 == 32.2	11/11/25 19:50 == 47.8	11/12/25 0:20 == 47.8	11/12/25 4:50 == 47.8
11/11/25 15:25 == 32.2	11/11/25 19:55 == 47.6	11/12/25 0:25 == 47.8	11/12/25 4:55 == 47.8

Pumpback Station Discharge (0364)

11/12/25 5:00 == 47.8	11/12/25 9:30 == 47.4	11/12/25 14:00 == 47.4	11/12/25 18:30 == 47.5
11/12/25 5:05 == 48	11/12/25 9:35 == 47.6	11/12/25 14:05 == 47.5	11/12/25 18:35 == 47.6
11/12/25 5:10 == 47.5	11/12/25 9:40 == 47.6	11/12/25 14:10 == 47.6	11/12/25 18:40 == 47.6
11/12/25 5:15 == 47.4	11/12/25 9:45 == 47.7	11/12/25 14:15 == 47.8	11/12/25 18:45 == 47.7
11/12/25 5:20 == 47.8	11/12/25 9:50 == 47.7	11/12/25 14:20 == 47.6	11/12/25 18:50 == 47.7
11/12/25 5:25 == 47.7	11/12/25 9:55 == 47.4	11/12/25 14:25 == 47.7	11/12/25 18:55 == 47.5
11/12/25 5:30 == 47.6	11/12/25 10:00 == 47.4	11/12/25 14:30 == 47.9	11/12/25 19:00 == 47.7
11/12/25 5:35 == 47.8	11/12/25 10:05 == 47.6	11/12/25 14:35 == 47.8	11/12/25 19:05 == 47.9
11/12/25 5:40 == 47.8	11/12/25 10:10 == 47.5	11/12/25 14:40 == 47.6	11/12/25 19:10 == 47.8
11/12/25 5:45 == 47.9	11/12/25 10:15 == 47.5	11/12/25 14:45 == 47.6	11/12/25 19:15 == 47.8
11/12/25 5:50 == 47.7	11/12/25 10:20 == 47.7	11/12/25 14:50 == 47.7	11/12/25 19:20 == 47.7
11/12/25 5:55 == 45	11/12/25 10:25 == 47.6	11/12/25 14:55 == 44.7	11/12/25 19:25 == 47.7
11/12/25 6:00 == 35.2	11/12/25 10:30 == 47.7	11/12/25 15:00 == 36.7	11/12/25 19:30 == 47.8
11/12/25 6:05 == 32.3	11/12/25 10:35 == 47.9	11/12/25 15:05 == 32.3	11/12/25 19:35 == 47.8
11/12/25 6:10 == 32.3	11/12/25 10:40 == 47.9	11/12/25 15:10 == 32.2	11/12/25 19:40 == 47.7
11/12/25 6:15 == 32.4	11/12/25 10:45 == 47.9	11/12/25 15:15 == 32.2	11/12/25 19:45 == 47.8
11/12/25 6:20 == 32.3	11/12/25 10:50 == 47.8	11/12/25 15:20 == 32.4	11/12/25 19:50 == 47.8
11/12/25 6:25 == 32.5	11/12/25 10:55 == 47.6	11/12/25 15:25 == 33.4	11/12/25 19:55 == 47.6
11/12/25 6:30 == 44.1	11/12/25 11:00 == 47.7	11/12/25 15:30 == 41.5	11/12/25 20:00 == 47.6
11/12/25 6:35 == 47.8	11/12/25 11:05 == 47.6	11/12/25 15:35 == 47.6	11/12/25 20:05 == 47.6
11/12/25 6:40 == 47	11/12/25 11:10 == 47.4	11/12/25 15:40 == 47.1	11/12/25 20:10 == 47.4
11/12/25 6:45 == 47.6	11/12/25 11:15 == 47.7	11/12/25 15:45 == 47.9	11/12/25 20:15 == 47.6
11/12/25 6:50 == 47.7	11/12/25 11:20 == 48	11/12/25 15:50 == 47.9	11/12/25 20:20 == 47.7
11/12/25 6:55 == 47.6	11/12/25 11:25 == 47.7	11/12/25 15:55 == 47.8	11/12/25 20:25 == 47.6
11/12/25 7:00 == 47.6	11/12/25 11:30 == 47.8	11/12/25 16:00 == 47.8	11/12/25 20:30 == 47.4
11/12/25 7:05 == 47.8	11/12/25 11:35 == 47.8	11/12/25 16:05 == 47.8	11/12/25 20:35 == 47.4
11/12/25 7:10 == 47.2	11/12/25 11:40 == 47.5	11/12/25 16:10 == 47.7	11/12/25 20:40 == 47.2
11/12/25 7:15 == 47.4	11/12/25 11:45 == 47.8	11/12/25 16:15 == 47.8	11/12/25 20:45 == 47.7
11/12/25 7:20 == 47.7	11/12/25 11:50 == 48	11/12/25 16:20 == 47.8	11/12/25 20:50 == 47.8
11/12/25 7:25 == 47.6	11/12/25 11:55 == 47.7	11/12/25 16:25 == 47.6	11/12/25 20:55 == 47.9
11/12/25 7:30 == 47.8	11/12/25 12:00 == 47.8	11/12/25 16:30 == 47.8	11/12/25 21:00 == 47.8
11/12/25 7:35 == 47.6	11/12/25 12:05 == 47.9	11/12/25 16:35 == 47.9	11/12/25 21:05 == 47.8
11/12/25 7:40 == 47.3	11/12/25 12:10 == 47.7	11/12/25 16:40 == 47.9	11/12/25 21:10 == 47.6
11/12/25 7:45 == 47.5	11/12/25 12:15 == 47.6	11/12/25 16:45 == 47.9	11/12/25 21:15 == 47.6
11/12/25 7:50 == 47.6	11/12/25 12:20 == 47.7	11/12/25 16:50 == 47.9	11/12/25 21:20 == 47.7
11/12/25 7:55 == 47.4	11/12/25 12:25 == 47.6	11/12/25 16:55 == 47.8	11/12/25 21:25 == 47.6
11/12/25 8:00 == 47.6	11/12/25 12:30 == 47.5	11/12/25 17:00 == 47.7	11/12/25 21:30 == 47.5
11/12/25 8:05 == 47.7	11/12/25 12:35 == 47.5	11/12/25 17:05 == 47.5	11/12/25 21:35 == 47.6
11/12/25 8:10 == 47.7	11/12/25 12:40 == 47.6	11/12/25 17:10 == 47.4	11/12/25 21:40 == 47.6
11/12/25 8:15 == 47.6	11/12/25 12:45 == 47.7	11/12/25 17:15 == 47.5	11/12/25 21:45 == 47.6
11/12/25 8:20 == 47.6	11/12/25 12:50 == 47.4	11/12/25 17:20 == 47.9	11/12/25 21:50 == 47.6
11/12/25 8:25 == 47.5	11/12/25 12:55 == 47.6	11/12/25 17:25 == 48	11/12/25 21:55 == 47.5
11/12/25 8:30 == 47.3	11/12/25 13:00 == 47.5	11/12/25 17:30 == 47.8	11/12/25 22:00 == 47.6
11/12/25 8:35 == 47.3	11/12/25 13:05 == 47.4	11/12/25 17:35 == 47.9	11/12/25 22:05 == 47.8
11/12/25 8:40 == 47.5	11/12/25 13:10 == 47.4	11/12/25 17:40 == 47.8	11/12/25 22:10 == 47.8
11/12/25 8:45 == 47.4	11/12/25 13:15 == 47.3	11/12/25 17:45 == 48	11/12/25 22:15 == 47.9
11/12/25 8:50 == 47.5	11/12/25 13:20 == 47.4	11/12/25 17:50 == 48	11/12/25 22:20 == 47.9
11/12/25 8:55 == 47.4	11/12/25 13:25 == 47.4	11/12/25 17:55 == 47.4	11/12/25 22:25 == 47.5
11/12/25 9:00 == 47.4	11/12/25 13:30 == 47.6	11/12/25 18:00 == 47.6	11/12/25 22:30 == 47.5
11/12/25 9:05 == 47.5	11/12/25 13:35 == 47.3	11/12/25 18:05 == 47.9	11/12/25 22:35 == 47.7
11/12/25 9:10 == 47.5	11/12/25 13:40 == 47.4	11/12/25 18:10 == 47.9	11/12/25 22:40 == 47.8
11/12/25 9:15 == 47.5	11/12/25 13:45 == 47.4	11/12/25 18:15 == 47.8	11/12/25 22:45 == 47.7
11/12/25 9:20 == 47.5	11/12/25 13:50 == 47.4	11/12/25 18:20 == 47.7	11/12/25 22:50 == 47.6
11/12/25 9:25 == 47.4	11/12/25 13:55 == 47.5	11/12/25 18:25 == 47.1	11/12/25 22:55 == 47.7

Pumpback Station Discharge (0364)

11/12/25 23:00 == 47.6	11/13/25 3:30 == 47.8	11/13/25 8:00 == 47.8	11/13/25 12:30 == 47.6
11/12/25 23:05 == 47.6	11/13/25 3:35 == 47.9	11/13/25 8:05 == 47.8	11/13/25 12:35 == 47.8
11/12/25 23:10 == 47.3	11/13/25 3:40 == 47.9	11/13/25 8:10 == 47.7	11/13/25 12:40 == 47.7
11/12/25 23:15 == 47.8	11/13/25 3:45 == 47.8	11/13/25 8:15 == 47.8	11/13/25 12:45 == 37.8
11/12/25 23:20 == 47.9	11/13/25 3:50 == 47.9	11/13/25 8:20 == 47.8	11/13/25 12:50 == 32.8
11/12/25 23:25 == 47.7	11/13/25 3:55 == 47.4	11/13/25 8:25 == 47.7	11/13/25 12:55 == 32.4
11/12/25 23:30 == 47.6	11/13/25 4:00 == 47.7	11/13/25 8:30 == 47.7	11/13/25 13:00 == 32.4
11/12/25 23:35 == 47.7	11/13/25 4:05 == 47.9	11/13/25 8:35 == 47.8	11/13/25 13:05 == 32.3
11/12/25 23:40 == 47.5	11/13/25 4:10 == 47.5	11/13/25 8:40 == 47.8	11/13/25 13:10 == 32.3
11/12/25 23:45 == 47.4	11/13/25 4:15 == 47.6	11/13/25 8:45 == 47.7	11/13/25 13:15 == 39.7
11/12/25 23:50 == 47.7	11/13/25 4:20 == 47.8	11/13/25 8:50 == 47.6	11/13/25 13:20 == 46.2
11/12/25 23:55 == 47.8	11/13/25 4:25 == 47.8	11/13/25 8:55 == 47.7	11/13/25 13:25 == 47.9
11/13/25 0:00 == 47.7	11/13/25 4:30 == 47.9	11/13/25 9:00 == 47.7	11/13/25 13:30 == 47.9
11/13/25 0:05 == 47.6	11/13/25 4:35 == 47.8	11/13/25 9:05 == 47.7	11/13/25 13:35 == 47.8
11/13/25 0:10 == 47.4	11/13/25 4:40 == 47.7	11/13/25 9:10 == 47.7	11/13/25 13:40 == 47.9
11/13/25 0:15 == 47.7	11/13/25 4:45 == 47.7	11/13/25 9:15 == 47.7	11/13/25 13:45 == 47.8
11/13/25 0:20 == 47.7	11/13/25 4:50 == 47.7	11/13/25 9:20 == 47.8	11/13/25 13:50 == 47.8
11/13/25 0:25 == 45.8	11/13/25 4:55 == 47.8	11/13/25 9:25 == 47.5	11/13/25 13:55 == 47.8
11/13/25 0:30 == 38	11/13/25 5:00 == 47.8	11/13/25 9:30 == 47.5	11/13/25 14:00 == 47.7
11/13/25 0:35 == 32.4	11/13/25 5:05 == 47.7	11/13/25 9:35 == 47.7	11/13/25 14:05 == 47.6
11/13/25 0:40 == 32.3	11/13/25 5:10 == 47.4	11/13/25 9:40 == 47.7	11/13/25 14:10 == 47.6
11/13/25 0:45 == 32.4	11/13/25 5:15 == 48	11/13/25 9:45 == 47.8	11/13/25 14:15 == 47.8
11/13/25 0:50 == 32.3	11/13/25 5:20 == 47.7	11/13/25 9:50 == 47.8	11/13/25 14:20 == 47.7
11/13/25 0:55 == 32.4	11/13/25 5:25 == 47.8	11/13/25 9:55 == 47.8	11/13/25 14:25 == 47.7
11/13/25 1:00 == 41	11/13/25 5:30 == 47.7	11/13/25 10:00 == 47.8	11/13/25 14:30 == 47.9
11/13/25 1:05 == 47.5	11/13/25 5:35 == 47.8	11/13/25 10:05 == 47.9	11/13/25 14:35 == 47.7
11/13/25 1:10 == 47.6	11/13/25 5:40 == 47.7	11/13/25 10:10 == 46.9	11/13/25 14:40 == 47.8
11/13/25 1:15 == 47.8	11/13/25 5:45 == 47.6	11/13/25 10:15 == 47.2	11/13/25 14:45 == 47.7
11/13/25 1:20 == 47.8	11/13/25 5:50 == 47.7	11/13/25 10:20 == 47.7	11/13/25 14:50 == 47.8
11/13/25 1:25 == 47.6	11/13/25 5:55 == 47.6	11/13/25 10:25 == 47.3	11/13/25 14:55 == 47.7
11/13/25 1:30 == 47.7	11/13/25 6:00 == 47.7	11/13/25 10:30 == 48	11/13/25 15:00 == 47.7
11/13/25 1:35 == 47.8	11/13/25 6:05 == 47.7	11/13/25 10:35 == 48.1	11/13/25 15:05 == 47.9
11/13/25 1:40 == 47.7	11/13/25 6:10 == 47.7	11/13/25 10:40 == 47.8	11/13/25 15:10 == 47.3
11/13/25 1:45 == 47.7	11/13/25 6:15 == 47.8	11/13/25 10:45 == 48	11/13/25 15:15 == 47.4
11/13/25 1:50 == 47.7	11/13/25 6:20 == 47.7	11/13/25 10:50 == 47.9	11/13/25 15:20 == 47.3
11/13/25 1:55 == 47.5	11/13/25 6:25 == 47.6	11/13/25 10:55 == 47.1	11/13/25 15:25 == 47.4
11/13/25 2:00 == 47.4	11/13/25 6:30 == 47.7	11/13/25 11:00 == 47.5	11/13/25 15:30 == 47.4
11/13/25 2:05 == 47.5	11/13/25 6:35 == 47.8	11/13/25 11:05 == 47.9	11/13/25 15:35 == 47.6
11/13/25 2:10 == 47.5	11/13/25 6:40 == 47.7	11/13/25 11:10 == 47.5	11/13/25 15:40 == 47.1
11/13/25 2:15 == 47.6	11/13/25 6:45 == 47.6	11/13/25 11:15 == 47.4	11/13/25 15:45 == 47.3
11/13/25 2:20 == 47.7	11/13/25 6:50 == 47.8	11/13/25 11:20 == 47.7	11/13/25 15:50 == 47.6
11/13/25 2:25 == 47.5	11/13/25 6:55 == 47.8	11/13/25 11:25 == 47.9	11/13/25 15:55 == 47.5
11/13/25 2:30 == 47.4	11/13/25 7:00 == 47.7	11/13/25 11:30 == 47.9	11/13/25 16:00 == 47.5
11/13/25 2:35 == 47.7	11/13/25 7:05 == 47.7	11/13/25 11:35 == 47.8	11/13/25 16:05 == 47.6
11/13/25 2:40 == 47.9	11/13/25 7:10 == 45.6	11/13/25 11:40 == 47.5	11/13/25 16:10 == 47.6
11/13/25 2:45 == 47.8	11/13/25 7:15 == 39	11/13/25 11:45 == 47.5	11/13/25 16:15 == 47.5
11/13/25 2:50 == 47.7	11/13/25 7:20 == 32.3	11/13/25 11:50 == 47.7	11/13/25 16:20 == 47.3
11/13/25 2:55 == 47.5	11/13/25 7:25 == 32.3	11/13/25 11:55 == 47.7	11/13/25 16:25 == 47.3
11/13/25 3:00 == 47.8	11/13/25 7:30 == 32.3	11/13/25 12:00 == 47.9	11/13/25 16:30 == 47.5
11/13/25 3:05 == 47.8	11/13/25 7:35 == 32.3	11/13/25 12:05 == 47.9	11/13/25 16:35 == 47.6
11/13/25 3:10 == 47.8	11/13/25 7:40 == 32.7	11/13/25 12:10 == 47.8	11/13/25 16:40 == 47.6
11/13/25 3:15 == 48	11/13/25 7:45 == 38.8	11/13/25 12:15 == 47.7	11/13/25 16:45 == 47.5
11/13/25 3:20 == 47.9	11/13/25 7:50 == 47.8	11/13/25 12:20 == 47.7	11/13/25 16:50 == 47.7
11/13/25 3:25 == 47.5	11/13/25 7:55 == 48	11/13/25 12:25 == 47.6	11/13/25 16:55 == 47.6

Pumpback Station Discharge (0364)

11/13/25 17:00 == 47.4	11/13/25 21:30 == 47.4	11/14/25 2:00 == 32.1	11/14/25 6:30 == 47.5
11/13/25 17:05 == 47.5	11/13/25 21:35 == 47.4	11/14/25 2:05 == 32.2	11/14/25 6:35 == 47.6
11/13/25 17:10 == 47.1	11/13/25 21:40 == 47.5	11/14/25 2:10 == 32.5	11/14/25 6:40 == 47.4
11/13/25 17:15 == 47.6	11/13/25 21:45 == 47.5	11/14/25 2:15 == 35.4	11/14/25 6:45 == 47.3
11/13/25 17:20 == 47.5	11/13/25 21:50 == 47.4	11/14/25 2:20 == 47.3	11/14/25 6:50 == 47.3
11/13/25 17:25 == 47.7	11/13/25 21:55 == 47	11/14/25 2:25 == 47.1	11/14/25 6:55 == 47.2
11/13/25 17:30 == 47.7	11/13/25 22:00 == 47.6	11/14/25 2:30 == 47.6	11/14/25 7:00 == 47.4
11/13/25 17:35 == 47.5	11/13/25 22:05 == 47.8	11/14/25 2:35 == 47.8	11/14/25 7:05 == 47.4
11/13/25 17:40 == 47.6	11/13/25 22:10 == 47.7	11/14/25 2:40 == 47.6	11/14/25 7:10 == 47.2
11/13/25 17:45 == 47.7	11/13/25 22:15 == 47.6	11/14/25 2:45 == 47.7	11/14/25 7:15 == 47.1
11/13/25 17:50 == 47.7	11/13/25 22:20 == 47.8	11/14/25 2:50 == 47.9	11/14/25 7:20 == 47.6
11/13/25 17:55 == 47.2	11/13/25 22:25 == 47.4	11/14/25 2:55 == 47	11/14/25 7:25 == 47.7
11/13/25 18:00 == 47.6	11/13/25 22:30 == 47.5	11/14/25 3:00 == 47.2	11/14/25 7:30 == 47.6
11/13/25 18:05 == 47.8	11/13/25 22:35 == 47.4	11/14/25 3:05 == 47.5	11/14/25 7:35 == 47.7
11/13/25 18:10 == 47.6	11/13/25 22:40 == 47.2	11/14/25 3:10 == 47.5	11/14/25 7:40 == 46.9
11/13/25 18:15 == 47.6	11/13/25 22:45 == 47.2	11/14/25 3:15 == 47.5	11/14/25 7:45 == 47.3
11/13/25 18:20 == 47.6	11/13/25 22:50 == 47.6	11/14/25 3:20 == 47.6	11/14/25 7:50 == 47.8
11/13/25 18:25 == 47.3	11/13/25 22:55 == 47.5	11/14/25 3:25 == 47.6	11/14/25 7:55 == 47.5
11/13/25 18:30 == 47.1	11/13/25 23:00 == 47.3	11/14/25 3:30 == 47.7	11/14/25 8:00 == 47.4
11/13/25 18:35 == 47.2	11/13/25 23:05 == 47.5	11/14/25 3:35 == 47.8	11/14/25 8:05 == 47.5
11/13/25 18:40 == 47.4	11/13/25 23:10 == 47.6	11/14/25 3:40 == 47.7	11/14/25 8:10 == 47.4
11/13/25 18:45 == 47.6	11/13/25 23:15 == 47.6	11/14/25 3:45 == 47.6	11/14/25 8:15 == 47.3
11/13/25 18:50 == 47.6	11/13/25 23:20 == 47.7	11/14/25 3:50 == 47.5	11/14/25 8:20 == 47.3
11/13/25 18:55 == 47.7	11/13/25 23:25 == 47.5	11/14/25 3:55 == 47.3	11/14/25 8:25 == 47.3
11/13/25 19:00 == 47.8	11/13/25 23:30 == 47.5	11/14/25 4:00 == 47.5	11/14/25 8:30 == 47.1
11/13/25 19:05 == 47.7	11/13/25 23:35 == 47.4	11/14/25 4:05 == 47.6	11/14/25 8:35 == 47.2
11/13/25 19:10 == 47.5	11/13/25 23:40 == 47.5	11/14/25 4:10 == 47.5	11/14/25 8:40 == 47.3
11/13/25 19:15 == 47.6	11/13/25 23:45 == 47.6	11/14/25 4:15 == 47.7	11/14/25 8:45 == 47
11/13/25 19:20 == 47.6	11/13/25 23:50 == 47.6	11/14/25 4:20 == 47.7	11/14/25 8:50 == 47.2
11/13/25 19:25 == 47.2	11/13/25 23:55 == 47.4	11/14/25 4:25 == 47.7	11/14/25 8:55 == 47.3
11/13/25 19:30 == 47.5	11/14/25 0:00 == 47.6	11/14/25 4:30 == 47.7	11/14/25 9:00 == 47.1
11/13/25 19:35 == 47.6	11/14/25 0:05 == 47.8	11/14/25 4:35 == 47.8	11/14/25 9:05 == 47.1
11/13/25 19:40 == 47.6	11/14/25 0:10 == 47.6	11/14/25 4:40 == 47.6	11/14/25 9:10 == 47.3
11/13/25 19:45 == 47.5	11/14/25 0:15 == 47.3	11/14/25 4:45 == 47.7	11/14/25 9:15 == 47.2
11/13/25 19:50 == 47.6	11/14/25 0:20 == 47.4	11/14/25 4:50 == 47.8	11/14/25 9:20 == 47.4
11/13/25 19:55 == 47.5	11/14/25 0:25 == 47.7	11/14/25 4:55 == 47.8	11/14/25 9:25 == 47.3
11/13/25 20:00 == 47.4	11/14/25 0:30 == 47.7	11/14/25 5:00 == 47.8	11/14/25 9:30 == 47.2
11/13/25 20:05 == 47.3	11/14/25 0:35 == 47.8	11/14/25 5:05 == 47.8	11/14/25 9:35 == 47.4
11/13/25 20:10 == 47.4	11/14/25 0:40 == 47.5	11/14/25 5:10 == 47.3	11/14/25 9:40 == 47.3
11/13/25 20:15 == 47.4	11/14/25 0:45 == 47.5	11/14/25 5:15 == 47.6	11/14/25 9:45 == 47.2
11/13/25 20:20 == 47.3	11/14/25 0:50 == 47.6	11/14/25 5:20 == 47.6	11/14/25 9:50 == 47.2
11/13/25 20:25 == 47.3	11/14/25 0:55 == 47.5	11/14/25 5:25 == 47.3	11/14/25 9:55 == 47.3
11/13/25 20:30 == 47.2	11/14/25 1:00 == 47.4	11/14/25 5:30 == 47.4	11/14/25 10:00 == 47.5
11/13/25 20:35 == 47.2	11/14/25 1:05 == 47.6	11/14/25 5:35 == 47.7	11/14/25 10:05 == 47.6
11/13/25 20:40 == 47.1	11/14/25 1:10 == 47.4	11/14/25 5:40 == 47.6	11/14/25 10:10 == 47.2
11/13/25 20:45 == 47.2	11/14/25 1:15 == 47.4	11/14/25 5:45 == 47.6	11/14/25 10:15 == 47.2
11/13/25 20:50 == 47.6	11/14/25 1:20 == 47.6	11/14/25 5:50 == 47.8	11/14/25 10:20 == 47.8
11/13/25 20:55 == 47.6	11/14/25 1:25 == 47.4	11/14/25 5:55 == 47.6	11/14/25 10:25 == 47.5
11/13/25 21:00 == 47.5	11/14/25 1:30 == 47.3	11/14/25 6:00 == 47.5	11/14/25 10:30 == 47.3
11/13/25 21:05 == 47.5	11/14/25 1:35 == 47.2	11/14/25 6:05 == 47.5	11/14/25 10:35 == 47.7
11/13/25 21:10 == 47.4	11/14/25 1:40 == 46.5	11/14/25 6:10 == 47.5	11/14/25 10:40 == 47.7
11/13/25 21:15 == 47.4	11/14/25 1:45 == 41.4	11/14/25 6:15 == 47.5	11/14/25 10:45 == 47.7
11/13/25 21:20 == 47.2	11/14/25 1:50 == 32.1	11/14/25 6:20 == 47.5	11/14/25 10:50 == 47.5
11/13/25 21:25 == 47.2	11/14/25 1:55 == 32.1	11/14/25 6:25 == 47.6	11/14/25 10:55 == 47.2

Pumpback Station Discharge (0364)

11/14/25 11:00 == 47.4	11/14/25 15:30 == 47.1	11/14/25 20:00 == 47.2	11/15/25 0:30 == 46.9
11/14/25 11:05 == 47.4	11/14/25 15:35 == 47	11/14/25 20:05 == 47	11/15/25 0:35 == 46.9
11/14/25 11:10 == 47.1	11/14/25 15:40 == 47.1	11/14/25 20:10 == 47.1	11/15/25 0:40 == 47
11/14/25 11:15 == 47.6	11/14/25 15:45 == 47.1	11/14/25 20:15 == 47.1	11/15/25 0:45 == 46.9
11/14/25 11:20 == 47.5	11/14/25 15:50 == 47	11/14/25 20:20 == 47.1	11/15/25 0:50 == 46.9
11/14/25 11:25 == 47.5	11/14/25 15:55 == 46.9	11/14/25 20:25 == 46.8	11/15/25 0:55 == 46.9
11/14/25 11:30 == 43.3	11/14/25 16:00 == 46.8	11/14/25 20:30 == 46.9	11/15/25 1:00 == 46.9
11/14/25 11:35 == 32.1	11/14/25 16:05 == 47	11/14/25 20:35 == 46.9	11/15/25 1:05 == 46.9
11/14/25 11:40 == 32.2	11/14/25 16:10 == 46.9	11/14/25 20:40 == 46.9	11/15/25 1:10 == 47
11/14/25 11:45 == 32.3	11/14/25 16:15 == 46.7	11/14/25 20:45 == 46.9	11/15/25 1:15 == 47
11/14/25 11:50 == 32	11/14/25 16:20 == 47.1	11/14/25 20:50 == 47	11/15/25 1:20 == 46.9
11/14/25 11:55 == 32.3	11/14/25 16:25 == 46.9	11/14/25 20:55 == 47.4	11/15/25 1:25 == 47.1
11/14/25 12:00 == 35.6	11/14/25 16:30 == 46.9	11/14/25 21:00 == 47.4	11/15/25 1:30 == 47
11/14/25 12:05 == 45.4	11/14/25 16:35 == 47.1	11/14/25 21:05 == 47.3	11/15/25 1:35 == 46.9
11/14/25 12:10 == 47.4	11/14/25 16:40 == 47.3	11/14/25 21:10 == 47.1	11/15/25 1:40 == 46.9
11/14/25 12:15 == 47.4	11/14/25 16:45 == 47.1	11/14/25 21:15 == 47.1	11/15/25 1:45 == 47
11/14/25 12:20 == 47.3	11/14/25 16:50 == 47.3	11/14/25 21:20 == 47.1	11/15/25 1:50 == 47
11/14/25 12:25 == 47.3	11/14/25 16:55 == 47.4	11/14/25 21:25 == 47	11/15/25 1:55 == 47
11/14/25 12:30 == 47.3	11/14/25 17:00 == 47.5	11/14/25 21:30 == 47	11/15/25 2:00 == 47
11/14/25 12:35 == 47.2	11/14/25 17:05 == 47.4	11/14/25 21:35 == 46.9	11/15/25 2:05 == 46.9
11/14/25 12:40 == 47.3	11/14/25 17:10 == 47.3	11/14/25 21:40 == 47.1	11/15/25 2:10 == 46.9
11/14/25 12:45 == 47.2	11/14/25 17:15 == 47.3	11/14/25 21:45 == 47.1	11/15/25 2:15 == 46.9
11/14/25 12:50 == 47.1	11/14/25 17:20 == 47.3	11/14/25 21:50 == 47.2	11/15/25 2:20 == 47
11/14/25 12:55 == 47.1	11/14/25 17:25 == 47.3	11/14/25 21:55 == 47.3	11/15/25 2:25 == 47.1
11/14/25 13:00 == 47.1	11/14/25 17:30 == 47.3	11/14/25 22:00 == 47.2	11/15/25 2:30 == 47.1
11/14/25 13:05 == 47	11/14/25 17:35 == 47.3	11/14/25 22:05 == 47.2	11/15/25 2:35 == 47
11/14/25 13:10 == 47.1	11/14/25 17:40 == 47.1	11/14/25 22:10 == 47.2	11/15/25 2:40 == 47.1
11/14/25 13:15 == 47.2	11/14/25 17:45 == 47.1	11/14/25 22:15 == 47.3	11/15/25 2:45 == 47.1
11/14/25 13:20 == 47.2	11/14/25 17:50 == 47.3	11/14/25 22:20 == 47.2	11/15/25 2:50 == 47
11/14/25 13:25 == 47.2	11/14/25 17:55 == 47.2	11/14/25 22:25 == 47	11/15/25 2:55 == 46.9
11/14/25 13:30 == 47	11/14/25 18:00 == 47.2	11/14/25 22:30 == 46.9	11/15/25 3:00 == 47
11/14/25 13:35 == 47	11/14/25 18:05 == 47.2	11/14/25 22:35 == 46.9	11/15/25 3:05 == 47.3
11/14/25 13:40 == 47.1	11/14/25 18:10 == 47	11/14/25 22:40 == 47	11/15/25 3:10 == 47.3
11/14/25 13:45 == 47.3	11/14/25 18:15 == 46.9	11/14/25 22:45 == 46.9	11/15/25 3:15 == 47.3
11/14/25 13:50 == 47	11/14/25 18:20 == 46.9	11/14/25 22:50 == 46.9	11/15/25 3:20 == 47.3
11/14/25 13:55 == 47.2	11/14/25 18:25 == 46.9	11/14/25 22:55 == 47	11/15/25 3:25 == 47.3
11/14/25 14:00 == 47.2	11/14/25 18:30 == 46.9	11/14/25 23:00 == 47	11/15/25 3:30 == 47.3
11/14/25 14:05 == 47.3	11/14/25 18:35 == 46.9	11/14/25 23:05 == 47	11/15/25 3:35 == 47.3
11/14/25 14:10 == 47	11/14/25 18:40 == 46.9	11/14/25 23:10 == 46.8	11/15/25 3:40 == 47.3
11/14/25 14:15 == 47.2	11/14/25 18:45 == 47.1	11/14/25 23:15 == 47	11/15/25 3:45 == 47.2
11/14/25 14:20 == 47.1	11/14/25 18:50 == 47.1	11/14/25 23:20 == 46.9	11/15/25 3:50 == 47.2
11/14/25 14:25 == 47.1	11/14/25 18:55 == 47	11/14/25 23:25 == 46.9	11/15/25 3:55 == 47.3
11/14/25 14:30 == 47	11/14/25 19:00 == 47.1	11/14/25 23:30 == 47	11/15/25 4:00 == 47.3
11/14/25 14:35 == 46.8	11/14/25 19:05 == 47.3	11/14/25 23:35 == 46.9	11/15/25 4:05 == 47.1
11/14/25 14:40 == 46.9	11/14/25 19:10 == 47.2	11/14/25 23:40 == 47	11/15/25 4:10 == 47.3
11/14/25 14:45 == 46.8	11/14/25 19:15 == 47.1	11/14/25 23:45 == 47	11/15/25 4:15 == 47.3
11/14/25 14:50 == 46.9	11/14/25 19:20 == 47.2	11/14/25 23:50 == 47	11/15/25 4:20 == 47.4
11/14/25 14:55 == 47	11/14/25 19:25 == 47.1	11/14/25 23:55 == 47	11/15/25 4:25 == 47.3
11/14/25 15:00 == 46.9	11/14/25 19:30 == 47.2	11/15/25 0:00 == 46.8	11/15/25 4:30 == 47.2
11/14/25 15:05 == 46.9	11/14/25 19:35 == 47.3	11/15/25 0:05 == 46.9	11/15/25 4:35 == 47.3
11/14/25 15:10 == 47	11/14/25 19:40 == 47.2	11/15/25 0:10 == 46.8	11/15/25 4:40 == 47.1
11/14/25 15:15 == 47	11/14/25 19:45 == 47.2	11/15/25 0:15 == 46.8	11/15/25 4:45 == 47.1
11/14/25 15:20 == 47.1	11/14/25 19:50 == 47.1	11/15/25 0:20 == 46.8	11/15/25 4:50 == 47.2
11/14/25 15:25 == 47.2	11/14/25 19:55 == 47.2	11/15/25 0:25 == 46.9	11/15/25 4:55 == 47.1

Pumpback Station Discharge (0364)

11/15/25 5:00 == 47.1	11/15/25 9:30 == 47.2	11/15/25 14:00 == 47	11/15/25 18:30 == 46.9
11/15/25 5:05 == 47	11/15/25 9:35 == 47.2	11/15/25 14:05 == 47	11/15/25 18:35 == 46.9
11/15/25 5:10 == 47.1	11/15/25 9:40 == 47.1	11/15/25 14:10 == 47.1	11/15/25 18:40 == 46.8
11/15/25 5:15 == 47.3	11/15/25 9:45 == 47.2	11/15/25 14:15 == 47.1	11/15/25 18:45 == 46.9
11/15/25 5:20 == 47.2	11/15/25 9:50 == 47.3	11/15/25 14:20 == 47.1	11/15/25 18:50 == 47
11/15/25 5:25 == 47.2	11/15/25 9:55 == 47.3	11/15/25 14:25 == 47.1	11/15/25 18:55 == 47
11/15/25 5:30 == 47.1	11/15/25 10:00 == 47.2	11/15/25 14:30 == 46.9	11/15/25 19:00 == 47.1
11/15/25 5:35 == 47	11/15/25 10:05 == 47.2	11/15/25 14:35 == 46.8	11/15/25 19:05 == 47.1
11/15/25 5:40 == 47	11/15/25 10:10 == 47.2	11/15/25 14:40 == 46.8	11/15/25 19:10 == 47
11/15/25 5:45 == 47.1	11/15/25 10:15 == 47.2	11/15/25 14:45 == 46.8	11/15/25 19:15 == 47
11/15/25 5:50 == 46.9	11/15/25 10:20 == 47.2	11/15/25 14:50 == 46.8	11/15/25 19:20 == 47.1
11/15/25 5:55 == 47.1	11/15/25 10:25 == 47.1	11/15/25 14:55 == 46.8	11/15/25 19:25 == 47.1
11/15/25 6:00 == 47.3	11/15/25 10:30 == 47.2	11/15/25 15:00 == 46.6	11/15/25 19:30 == 47.2
11/15/25 6:05 == 47.1	11/15/25 10:35 == 47	11/15/25 15:05 == 46.9	11/15/25 19:35 == 47.1
11/15/25 6:10 == 47.1	11/15/25 10:40 == 47.2	11/15/25 15:10 == 47	11/15/25 19:40 == 47
11/15/25 6:15 == 47.2	11/15/25 10:45 == 47	11/15/25 15:15 == 46.7	11/15/25 19:45 == 47.1
11/15/25 6:20 == 46.9	11/15/25 10:50 == 47.2	11/15/25 15:20 == 47	11/15/25 19:50 == 47.1
11/15/25 6:25 == 47	11/15/25 10:55 == 47.2	11/15/25 15:25 == 46.8	11/15/25 19:55 == 47
11/15/25 6:30 == 47.1	11/15/25 11:00 == 47.3	11/15/25 15:30 == 47	11/15/25 20:00 == 47
11/15/25 6:35 == 47.1	11/15/25 11:05 == 47.1	11/15/25 15:35 == 46.8	11/15/25 20:05 == 47.1
11/15/25 6:40 == 47.1	11/15/25 11:10 == 47.1	11/15/25 15:40 == 46.8	11/15/25 20:10 == 47.1
11/15/25 6:45 == 47.2	11/15/25 11:15 == 47.2	11/15/25 15:45 == 46.9	11/15/25 20:15 == 47.1
11/15/25 6:50 == 47.2	11/15/25 11:20 == 47.2	11/15/25 15:50 == 46.8	11/15/25 20:20 == 47.1
11/15/25 6:55 == 47.1	11/15/25 11:25 == 47.2	11/15/25 15:55 == 46.9	11/15/25 20:25 == 47
11/15/25 7:00 == 47.2	11/15/25 11:30 == 47.1	11/15/25 16:00 == 47.1	11/15/25 20:30 == 46.9
11/15/25 7:05 == 47.2	11/15/25 11:35 == 47.1	11/15/25 16:05 == 46.8	11/15/25 20:35 == 46.9
11/15/25 7:10 == 47	11/15/25 11:40 == 47.1	11/15/25 16:10 == 46.8	11/15/25 20:40 == 47
11/15/25 7:15 == 47.1	11/15/25 11:45 == 47.1	11/15/25 16:15 == 46.8	11/15/25 20:45 == 47
11/15/25 7:20 == 47.2	11/15/25 11:50 == 47.2	11/15/25 16:20 == 46.7	11/15/25 20:50 == 47.1
11/15/25 7:25 == 47.1	11/15/25 11:55 == 47.2	11/15/25 16:25 == 46.9	11/15/25 20:55 == 47.2
11/15/25 7:30 == 47.1	11/15/25 12:00 == 47.1	11/15/25 16:30 == 47.3	11/15/25 21:00 == 47.1
11/15/25 7:35 == 47.2	11/15/25 12:05 == 47.1	11/15/25 16:35 == 47.3	11/15/25 21:05 == 47.2
11/15/25 7:40 == 47.2	11/15/25 12:10 == 47.1	11/15/25 16:40 == 47.2	11/15/25 21:10 == 47.2
11/15/25 7:45 == 47.2	11/15/25 12:15 == 47.1	11/15/25 16:45 == 47.2	11/15/25 21:15 == 47.1
11/15/25 7:50 == 46.9	11/15/25 12:20 == 47	11/15/25 16:50 == 47.1	11/15/25 21:20 == 47.1
11/15/25 7:55 == 46.7	11/15/25 12:25 == 47	11/15/25 16:55 == 47	11/15/25 21:25 == 47.1
11/15/25 8:00 == 46.9	11/15/25 12:30 == 47	11/15/25 17:00 == 47.2	11/15/25 21:30 == 47.1
11/15/25 8:05 == 46.9	11/15/25 12:35 == 47.1	11/15/25 17:05 == 47.2	11/15/25 21:35 == 47.1
11/15/25 8:10 == 46.8	11/15/25 12:40 == 47.1	11/15/25 17:10 == 47.2	11/15/25 21:40 == 47.1
11/15/25 8:15 == 47	11/15/25 12:45 == 47	11/15/25 17:15 == 47.2	11/15/25 21:45 == 47
11/15/25 8:20 == 47	11/15/25 12:50 == 46.9	11/15/25 17:20 == 47.1	11/15/25 21:50 == 47.1
11/15/25 8:25 == 46.9	11/15/25 12:55 == 47	11/15/25 17:25 == 47.2	11/15/25 21:55 == 47.1
11/15/25 8:30 == 47	11/15/25 13:00 == 46.9	11/15/25 17:30 == 47.2	11/15/25 22:00 == 46.8
11/15/25 8:35 == 46.9	11/15/25 13:05 == 47.2	11/15/25 17:35 == 47.1	11/15/25 22:05 == 47.3
11/15/25 8:40 == 46.9	11/15/25 13:10 == 46.9	11/15/25 17:40 == 47.3	11/15/25 22:10 == 47.3
11/15/25 8:45 == 47	11/15/25 13:15 == 47	11/15/25 17:45 == 47.2	11/15/25 22:15 == 47.2
11/15/25 8:50 == 46.9	11/15/25 13:20 == 46.9	11/15/25 17:50 == 47.2	11/15/25 22:20 == 47.1
11/15/25 8:55 == 47	11/15/25 13:25 == 47.1	11/15/25 17:55 == 47	11/15/25 22:25 == 46.9
11/15/25 9:00 == 46.9	11/15/25 13:30 == 47.1	11/15/25 18:00 == 47.2	11/15/25 22:30 == 46.9
11/15/25 9:05 == 46.9	11/15/25 13:35 == 47	11/15/25 18:05 == 47.4	11/15/25 22:35 == 46.9
11/15/25 9:10 == 46.8	11/15/25 13:40 == 47	11/15/25 18:10 == 46.9	11/15/25 22:40 == 47
11/15/25 9:15 == 46.8	11/15/25 13:45 == 47	11/15/25 18:15 == 46.8	11/15/25 22:45 == 46.9
11/15/25 9:20 == 46.9	11/15/25 13:50 == 47	11/15/25 18:20 == 47	11/15/25 22:50 == 47
11/15/25 9:25 == 46.9	11/15/25 13:55 == 47	11/15/25 18:25 == 46.9	11/15/25 22:55 == 46.8

Pumpback Station Discharge (0364)

11/15/25 23:00 == 47	11/16/25 3:30 == 47.2	11/16/25 8:00 == 46.7	11/16/25 12:30 == 47.3
11/15/25 23:05 == 47.1	11/16/25 3:35 == 47.3	11/16/25 8:05 == 47	11/16/25 12:35 == 47.2
11/15/25 23:10 == 47.2	11/16/25 3:40 == 47.4	11/16/25 8:10 == 46.9	11/16/25 12:40 == 47.3
11/15/25 23:15 == 47.1	11/16/25 3:45 == 47.4	11/16/25 8:15 == 47	11/16/25 12:45 == 47.1
11/15/25 23:20 == 47.1	11/16/25 3:50 == 47.4	11/16/25 8:20 == 47	11/16/25 12:50 == 47
11/15/25 23:25 == 47.1	11/16/25 3:55 == 47.3	11/16/25 8:25 == 47	11/16/25 12:55 == 47.3
11/15/25 23:30 == 47	11/16/25 4:00 == 47.2	11/16/25 8:30 == 46.9	11/16/25 13:00 == 47.3
11/15/25 23:35 == 47	11/16/25 4:05 == 47.4	11/16/25 8:35 == 47	11/16/25 13:05 == 47.3
11/15/25 23:40 == 47.1	11/16/25 4:10 == 47.4	11/16/25 8:40 == 47.1	11/16/25 13:10 == 47.4
11/15/25 23:45 == 47	11/16/25 4:15 == 47.2	11/16/25 8:45 == 47.1	11/16/25 13:15 == 47.4
11/15/25 23:50 == 46.9	11/16/25 4:20 == 47.1	11/16/25 8:50 == 47.1	11/16/25 13:20 == 47.3
11/15/25 23:55 == 47	11/16/25 4:25 == 47.3	11/16/25 8:55 == 47	11/16/25 13:25 == 47.2
11/16/25 0:00 == 47	11/16/25 4:30 == 47.4	11/16/25 9:00 == 47	11/16/25 13:30 == 47.2
11/16/25 0:05 == 47	11/16/25 4:35 == 47.3	11/16/25 9:05 == 47	11/16/25 13:35 == 47.2
11/16/25 0:10 == 46.9	11/16/25 4:40 == 47.3	11/16/25 9:10 == 46.9	11/16/25 13:40 == 47.3
11/16/25 0:15 == 46.9	11/16/25 4:45 == 47.2	11/16/25 9:15 == 46.9	11/16/25 13:45 == 47.3
11/16/25 0:20 == 46.9	11/16/25 4:50 == 47.3	11/16/25 9:20 == 47.1	11/16/25 13:50 == 47.2
11/16/25 0:25 == 47	11/16/25 4:55 == 47.4	11/16/25 9:25 == 47	11/16/25 13:55 == 47.1
11/16/25 0:30 == 46.9	11/16/25 5:00 == 47.2	11/16/25 9:30 == 47.1	11/16/25 14:00 == 47.2
11/16/25 0:35 == 46.8	11/16/25 5:05 == 47.3	11/16/25 9:35 == 47.3	11/16/25 14:05 == 47.1
11/16/25 0:40 == 46.9	11/16/25 5:10 == 47.1	11/16/25 9:40 == 47.4	11/16/25 14:10 == 47.2
11/16/25 0:45 == 46.9	11/16/25 5:15 == 47.3	11/16/25 9:45 == 47.3	11/16/25 14:15 == 47.2
11/16/25 0:50 == 46.9	11/16/25 5:20 == 47	11/16/25 9:50 == 47.2	11/16/25 14:20 == 47.3
11/16/25 0:55 == 46.9	11/16/25 5:25 == 47.1	11/16/25 9:55 == 47.2	11/16/25 14:25 == 47.4
11/16/25 1:00 == 46.9	11/16/25 5:30 == 47.3	11/16/25 10:00 == 47.3	11/16/25 14:30 == 47.2
11/16/25 1:05 == 46.9	11/16/25 5:35 == 47.2	11/16/25 10:05 == 47.2	11/16/25 14:35 == 47
11/16/25 1:10 == 47	11/16/25 5:40 == 47.2	11/16/25 10:10 == 47.4	11/16/25 14:40 == 46.8
11/16/25 1:15 == 47.1	11/16/25 5:45 == 47.3	11/16/25 10:15 == 47.4	11/16/25 14:45 == 47
11/16/25 1:20 == 47	11/16/25 5:50 == 47.3	11/16/25 10:20 == 47.5	11/16/25 14:50 == 46.9
11/16/25 1:25 == 46.9	11/16/25 5:55 == 47.3	11/16/25 10:25 == 47.4	11/16/25 14:55 == 46.8
11/16/25 1:30 == 47	11/16/25 6:00 == 47.2	11/16/25 10:30 == 47.3	11/16/25 15:00 == 47.1
11/16/25 1:35 == 46.9	11/16/25 6:05 == 47.3	11/16/25 10:35 == 47.4	11/16/25 15:05 == 47.2
11/16/25 1:40 == 47.1	11/16/25 6:10 == 47.1	11/16/25 10:40 == 47.4	11/16/25 15:10 == 47
11/16/25 1:45 == 47.1	11/16/25 6:15 == 47.1	11/16/25 10:45 == 47.4	11/16/25 15:15 == 47
11/16/25 1:50 == 46.9	11/16/25 6:20 == 47.1	11/16/25 10:50 == 47.4	11/16/25 15:20 == 47
11/16/25 1:55 == 46.9	11/16/25 6:25 == 47.2	11/16/25 10:55 == 47.4	11/16/25 15:25 == 46.8
11/16/25 2:00 == 47	11/16/25 6:30 == 47.2	11/16/25 11:00 == 47.4	11/16/25 15:30 == 47
11/16/25 2:05 == 47	11/16/25 6:35 == 47.2	11/16/25 11:05 == 47.4	11/16/25 15:35 == 47.1
11/16/25 2:10 == 47	11/16/25 6:40 == 47.2	11/16/25 11:10 == 47.3	11/16/25 15:40 == 47
11/16/25 2:15 == 47	11/16/25 6:45 == 47.2	11/16/25 11:15 == 47.2	11/16/25 15:45 == 47.1
11/16/25 2:20 == 47	11/16/25 6:50 == 47.2	11/16/25 11:20 == 47.2	11/16/25 15:50 == 47
11/16/25 2:25 == 46.9	11/16/25 6:55 == 47.1	11/16/25 11:25 == 47.3	11/16/25 15:55 == 47.1
11/16/25 2:30 == 47	11/16/25 7:00 == 47.1	11/16/25 11:30 == 47.2	11/16/25 16:00 == 47.1
11/16/25 2:35 == 47	11/16/25 7:05 == 47.1	11/16/25 11:35 == 47.3	11/16/25 16:05 == 47
11/16/25 2:40 == 47.1	11/16/25 7:10 == 47.2	11/16/25 11:40 == 47.3	11/16/25 16:10 == 47
11/16/25 2:45 == 46.9	11/16/25 7:15 == 47.3	11/16/25 11:45 == 47.3	11/16/25 16:15 == 47
11/16/25 2:50 == 46.8	11/16/25 7:20 == 47.3	11/16/25 11:50 == 47.4	11/16/25 16:20 == 47.1
11/16/25 2:55 == 47	11/16/25 7:25 == 47.2	11/16/25 11:55 == 47.2	11/16/25 16:25 == 47
11/16/25 3:00 == 47.2	11/16/25 7:30 == 47.1	11/16/25 12:00 == 47.2	11/16/25 16:30 == 47.1
11/16/25 3:05 == 47.3	11/16/25 7:35 == 47.3	11/16/25 12:05 == 47.4	11/16/25 16:35 == 47.1
11/16/25 3:10 == 47.3	11/16/25 7:40 == 47.2	11/16/25 12:10 == 47	11/16/25 16:40 == 47.4
11/16/25 3:15 == 47.2	11/16/25 7:45 == 47.1	11/16/25 12:15 == 47.3	11/16/25 16:45 == 47.4
11/16/25 3:20 == 47.3	11/16/25 7:50 == 47	11/16/25 12:20 == 47.5	11/16/25 16:50 == 47.3
11/16/25 3:25 == 47.4	11/16/25 7:55 == 47.2	11/16/25 12:25 == 47.2	11/16/25 16:55 == 47.4

Pumpback Station Discharge (0364)

11/16/25 17:00 == 47.3	11/16/25 21:30 == 47.3	11/17/25 2:00 == 47	11/17/25 6:30 == 47.4
11/16/25 17:05 == 47.4	11/16/25 21:35 == 47.3	11/17/25 2:05 == 47	11/17/25 6:35 == 47.2
11/16/25 17:10 == 47.4	11/16/25 21:40 == 47.4	11/17/25 2:10 == 47.1	11/17/25 6:40 == 47.4
11/16/25 17:15 == 47.5	11/16/25 21:45 == 47.5	11/17/25 2:15 == 47.1	11/17/25 6:45 == 47.3
11/16/25 17:20 == 47.3	11/16/25 21:50 == 47.3	11/17/25 2:20 == 47.1	11/17/25 6:50 == 47.4
11/16/25 17:25 == 47.2	11/16/25 21:55 == 47.2	11/17/25 2:25 == 46.9	11/17/25 6:55 == 47.1
11/16/25 17:30 == 47.4	11/16/25 22:00 == 47.2	11/17/25 2:30 == 47.1	11/17/25 7:00 == 47.1
11/16/25 17:35 == 47.3	11/16/25 22:05 == 47.3	11/17/25 2:35 == 47	11/17/25 7:05 == 47.3
11/16/25 17:40 == 47.3	11/16/25 22:10 == 47.2	11/17/25 2:40 == 46.9	11/17/25 7:10 == 47.4
11/16/25 17:45 == 47.2	11/16/25 22:15 == 47.1	11/17/25 2:45 == 47.1	11/17/25 7:15 == 47.3
11/16/25 17:50 == 47.3	11/16/25 22:20 == 47.3	11/17/25 2:50 == 47	11/17/25 7:20 == 47.4
11/16/25 17:55 == 47.3	11/16/25 22:25 == 47.1	11/17/25 2:55 == 47.1	11/17/25 7:25 == 47.3
11/16/25 18:00 == 47.3	11/16/25 22:30 == 47	11/17/25 3:00 == 47.1	11/17/25 7:30 == 47.3
11/16/25 18:05 == 47.3	11/16/25 22:35 == 47.1	11/17/25 3:05 == 46.9	11/17/25 7:35 == 47.2
11/16/25 18:10 == 47.1	11/16/25 22:40 == 47.2	11/17/25 3:10 == 47.2	11/17/25 7:40 == 47.1
11/16/25 18:15 == 46.9	11/16/25 22:45 == 47.2	11/17/25 3:15 == 47.4	11/17/25 7:45 == 47.2
11/16/25 18:20 == 46.8	11/16/25 22:50 == 47.1	11/17/25 3:20 == 47.4	11/17/25 7:50 == 47.2
11/16/25 18:25 == 46.9	11/16/25 22:55 == 47	11/17/25 3:25 == 47.4	11/17/25 7:55 == 47.1
11/16/25 18:30 == 47.1	11/16/25 23:00 == 47	11/17/25 3:30 == 47.4	11/17/25 8:00 == 47.1
11/16/25 18:35 == 47.1	11/16/25 23:05 == 47.1	11/17/25 3:35 == 47.3	11/17/25 8:05 == 47
11/16/25 18:40 == 47	11/16/25 23:10 == 47.2	11/17/25 3:40 == 47.4	11/17/25 8:10 == 47.1
11/16/25 18:45 == 47.1	11/16/25 23:15 == 47.1	11/17/25 3:45 == 47.4	11/17/25 8:15 == 47.1
11/16/25 18:50 == 47.1	11/16/25 23:20 == 47.1	11/17/25 3:50 == 47.4	11/17/25 8:20 == 47.1
11/16/25 18:55 == 47.3	11/16/25 23:25 == 47	11/17/25 3:55 == 47.3	11/17/25 8:25 == 47.1
11/16/25 19:00 == 47.3	11/16/25 23:30 == 47	11/17/25 4:00 == 47.4	11/17/25 8:30 == 47
11/16/25 19:05 == 47.3	11/16/25 23:35 == 46.9	11/17/25 4:05 == 47.3	11/17/25 8:35 == 46.9
11/16/25 19:10 == 47.3	11/16/25 23:40 == 47	11/17/25 4:10 == 47.3	11/17/25 8:40 == 47
11/16/25 19:15 == 47.1	11/16/25 23:45 == 47.1	11/17/25 4:15 == 47.3	11/17/25 8:45 == 47
11/16/25 19:20 == 47.2	11/16/25 23:50 == 47	11/17/25 4:20 == 47.1	11/17/25 8:50 == 47.1
11/16/25 19:25 == 47.3	11/16/25 23:55 == 47	11/17/25 4:25 == 47.4	11/17/25 8:55 == 47.1
11/16/25 19:30 == 47.2	11/17/25 0:00 == 47	11/17/25 4:30 == 47.3	11/17/25 9:00 == 46.9
11/16/25 19:35 == 47.1	11/17/25 0:05 == 47	11/17/25 4:35 == 47.4	11/17/25 9:05 == 47
11/16/25 19:40 == 47.1	11/17/25 0:10 == 47	11/17/25 4:40 == 47.4	11/17/25 9:10 == 47
11/16/25 19:45 == 47.3	11/17/25 0:15 == 47.2	11/17/25 4:45 == 47.3	11/17/25 9:15 == 47.1
11/16/25 19:50 == 47.2	11/17/25 0:20 == 47.1	11/17/25 4:50 == 47.2	11/17/25 9:20 == 47
11/16/25 19:55 == 47.1	11/17/25 0:25 == 47	11/17/25 4:55 == 47.3	11/17/25 9:25 == 47
11/16/25 20:00 == 47.2	11/17/25 0:30 == 47.1	11/17/25 5:00 == 47.2	11/17/25 9:30 == 47.1
11/16/25 20:05 == 47.2	11/17/25 0:35 == 47.1	11/17/25 5:05 == 47.3	11/17/25 9:35 == 47
11/16/25 20:10 == 47.2	11/17/25 0:40 == 47.1	11/17/25 5:10 == 47.3	11/17/25 9:40 == 47.2
11/16/25 20:15 == 47.3	11/17/25 0:45 == 47	11/17/25 5:15 == 47.3	11/17/25 9:45 == 47.1
11/16/25 20:20 == 47.2	11/17/25 0:50 == 46.9	11/17/25 5:20 == 47.3	11/17/25 9:50 == 47.1
11/16/25 20:25 == 47	11/17/25 0:55 == 47	11/17/25 5:25 == 47.4	11/17/25 9:55 == 47.1
11/16/25 20:30 == 46.9	11/17/25 1:00 == 47.1	11/17/25 5:30 == 47.3	11/17/25 10:00 == 47.1
11/16/25 20:35 == 46.9	11/17/25 1:05 == 47.1	11/17/25 5:35 == 47.2	11/17/25 10:05 == 47.2
11/16/25 20:40 == 47	11/17/25 1:10 == 47.1	11/17/25 5:40 == 47.2	11/17/25 10:10 == 47.1
11/16/25 20:45 == 47.1	11/17/25 1:15 == 47.2	11/17/25 5:45 == 47.3	11/17/25 10:15 == 47
11/16/25 20:50 == 47.1	11/17/25 1:20 == 47.2	11/17/25 5:50 == 47.2	11/17/25 10:20 == 47
11/16/25 20:55 == 47.2	11/17/25 1:25 == 47	11/17/25 5:55 == 47.2	11/17/25 10:25 == 47
11/16/25 21:00 == 47.3	11/17/25 1:30 == 47	11/17/25 6:00 == 47.2	11/17/25 10:30 == 47
11/16/25 21:05 == 47.2	11/17/25 1:35 == 47	11/17/25 6:05 == 47.2	11/17/25 10:35 == 47
11/16/25 21:10 == 47.2	11/17/25 1:40 == 47	11/17/25 6:10 == 47.2	11/17/25 10:40 == 46.9
11/16/25 21:15 == 47.2	11/17/25 1:45 == 47	11/17/25 6:15 == 47.2	11/17/25 10:45 == 47
11/16/25 21:20 == 47.3	11/17/25 1:50 == 47	11/17/25 6:20 == 47.1	11/17/25 10:50 == 47
11/16/25 21:25 == 47.3	11/17/25 1:55 == 47	11/17/25 6:25 == 47.2	11/17/25 10:55 == 46.9

Pumpback Station Discharge (0364)

11/17/25 11:00 == 47.2	11/17/25 15:30 == 47	11/17/25 20:00 == 47.2	11/18/25 0:30 == 47.3
11/17/25 11:05 == 47.1	11/17/25 15:35 == 47	11/17/25 20:05 == 47.2	11/18/25 0:35 == 47.3
11/17/25 11:10 == 47	11/17/25 15:40 == 47.2	11/17/25 20:10 == 47.2	11/18/25 0:40 == 47.3
11/17/25 11:15 == 47.1	11/17/25 15:45 == 47.1	11/17/25 20:15 == 47.2	11/18/25 0:45 == 47.3
11/17/25 11:20 == 47.2	11/17/25 15:50 == 47.1	11/17/25 20:20 == 47.1	11/18/25 0:50 == 47.4
11/17/25 11:25 == 47.1	11/17/25 15:55 == 47	11/17/25 20:25 == 47.1	11/18/25 0:55 == 47.3
11/17/25 11:30 == 47.2	11/17/25 16:00 == 47.1	11/17/25 20:30 == 47.2	11/18/25 1:00 == 47.2
11/17/25 11:35 == 47.2	11/17/25 16:05 == 47.3	11/17/25 20:35 == 47.2	11/18/25 1:05 == 47.2
11/17/25 11:40 == 47.1	11/17/25 16:10 == 47	11/17/25 20:40 == 47.1	11/18/25 1:10 == 47.2
11/17/25 11:45 == 47	11/17/25 16:15 == 47.2	11/17/25 20:45 == 47.2	11/18/25 1:15 == 47.3
11/17/25 11:50 == 47.1	11/17/25 16:20 == 47.1	11/17/25 20:50 == 47.1	11/18/25 1:20 == 47.4
11/17/25 11:55 == 46.9	11/17/25 16:25 == 47	11/17/25 20:55 == 47.2	11/18/25 1:25 == 47.1
11/17/25 12:00 == 47	11/17/25 16:30 == 47.2	11/17/25 21:00 == 47.2	11/18/25 1:30 == 47.4
11/17/25 12:05 == 46.9	11/17/25 16:35 == 47.1	11/17/25 21:05 == 47.2	11/18/25 1:35 == 47.3
11/17/25 12:10 == 47	11/17/25 16:40 == 47.1	11/17/25 21:10 == 46.9	11/18/25 1:40 == 47.4
11/17/25 12:15 == 47	11/17/25 16:45 == 47.1	11/17/25 21:15 == 47.2	11/18/25 1:45 == 47.2
11/17/25 12:20 == 46.9	11/17/25 16:50 == 47	11/17/25 21:20 == 47.3	11/18/25 1:50 == 47.2
11/17/25 12:25 == 47.1	11/17/25 16:55 == 47.1	11/17/25 21:25 == 47.2	11/18/25 1:55 == 47.2
11/17/25 12:30 == 47.2	11/17/25 17:00 == 47	11/17/25 21:30 == 47	11/18/25 2:00 == 47.2
11/17/25 12:35 == 47.5	11/17/25 17:05 == 47.1	11/17/25 21:35 == 47.2	11/18/25 2:05 == 47.1
11/17/25 12:40 == 47.6	11/17/25 17:10 == 47.1	11/17/25 21:40 == 47.3	11/18/25 2:10 == 47.1
11/17/25 12:45 == 47.6	11/17/25 17:15 == 47.2	11/17/25 21:45 == 47.3	11/18/25 2:15 == 47.3
11/17/25 12:50 == 47.5	11/17/25 17:20 == 47.1	11/17/25 21:50 == 47.2	11/18/25 2:20 == 47.2
11/17/25 12:55 == 47.4	11/17/25 17:25 == 47.1	11/17/25 21:55 == 47.2	11/18/25 2:25 == 47.2
11/17/25 13:00 == 47.5	11/17/25 17:30 == 47.1	11/17/25 22:00 == 47.2	11/18/25 2:30 == 47.2
11/17/25 13:05 == 47.6	11/17/25 17:35 == 47	11/17/25 22:05 == 47.3	11/18/25 2:35 == 47.2
11/17/25 13:10 == 47.6	11/17/25 17:40 == 47.1	11/17/25 22:10 == 47.3	11/18/25 2:40 == 47.2
11/17/25 13:15 == 47.6	11/17/25 17:45 == 47.1	11/17/25 22:15 == 47.2	11/18/25 2:45 == 47.2
11/17/25 13:20 == 47.5	11/17/25 17:50 == 47.2	11/17/25 22:20 == 47.2	11/18/25 2:50 == 47.3
11/17/25 13:25 == 47.5	11/17/25 17:55 == 47.1	11/17/25 22:25 == 47.2	11/18/25 2:55 == 47.3
11/17/25 13:30 == 47.2	11/17/25 18:00 == 47.1	11/17/25 22:30 == 47.2	11/18/25 3:00 == 47.2
11/17/25 13:35 == 47.2	11/17/25 18:05 == 47.2	11/17/25 22:35 == 47.3	11/18/25 3:05 == 47.2
11/17/25 13:40 == 47.1	11/17/25 18:10 == 47.1	11/17/25 22:40 == 47.2	11/18/25 3:10 == 47.2
11/17/25 13:45 == 47	11/17/25 18:15 == 47.1	11/17/25 22:45 == 47.2	11/18/25 3:15 == 47.2
11/17/25 13:50 == 46.8	11/17/25 18:20 == 47.1	11/17/25 22:50 == 47.2	11/18/25 3:20 == 47.2
11/17/25 13:55 == 47	11/17/25 18:25 == 47.2	11/17/25 22:55 == 47.1	11/18/25 3:25 == 47.2
11/17/25 14:00 == 47.4	11/17/25 18:30 == 47.2	11/17/25 23:00 == 47.3	11/18/25 3:30 == 47.1
11/17/25 14:05 == 47.1	11/17/25 18:35 == 47.3	11/17/25 23:05 == 47.3	11/18/25 3:35 == 47.2
11/17/25 14:10 == 47.4	11/17/25 18:40 == 47.4	11/17/25 23:10 == 47.1	11/18/25 3:40 == 47.3
11/17/25 14:15 == 47.3	11/17/25 18:45 == 47.1	11/17/25 23:15 == 47.2	11/18/25 3:45 == 47.3
11/17/25 14:20 == 47.2	11/17/25 18:50 == 47.1	11/17/25 23:20 == 47.3	11/18/25 3:50 == 47.3
11/17/25 14:25 == 47.1	11/17/25 18:55 == 47.1	11/17/25 23:25 == 47.1	11/18/25 3:55 == 47.4
11/17/25 14:30 == 47.2	11/17/25 19:00 == 47.1	11/17/25 23:30 == 47.1	11/18/25 4:00 == 47.2
11/17/25 14:35 == 47.1	11/17/25 19:05 == 47.3	11/17/25 23:35 == 47.1	11/18/25 4:05 == 47.3
11/17/25 14:40 == 47.1	11/17/25 19:10 == 47.3	11/17/25 23:40 == 47.2	11/18/25 4:10 == 47.1
11/17/25 14:45 == 47.1	11/17/25 19:15 == 47.2	11/17/25 23:45 == 47.1	11/18/25 4:15 == 47.2
11/17/25 14:50 == 47.3	11/17/25 19:20 == 47.2	11/17/25 23:50 == 47	11/18/25 4:20 == 47.1
11/17/25 14:55 == 47.3	11/17/25 19:25 == 47.1	11/17/25 23:55 == 47.1	11/18/25 4:25 == 47.1
11/17/25 15:00 == 47.2	11/17/25 19:30 == 47.1	11/18/25 0:00 == 47.2	11/18/25 4:30 == 47.1
11/17/25 15:05 == 47.1	11/17/25 19:35 == 47	11/18/25 0:05 == 47.2	11/18/25 4:35 == 47.2
11/17/25 15:10 == 47.2	11/17/25 19:40 == 47	11/18/25 0:10 == 47.2	11/18/25 4:40 == 47.3
11/17/25 15:15 == 47.2	11/17/25 19:45 == 47.2	11/18/25 0:15 == 47.2	11/18/25 4:45 == 47.3
11/17/25 15:20 == 47.1	11/17/25 19:50 == 47.2	11/18/25 0:20 == 47.2	11/18/25 4:50 == 47.3
11/17/25 15:25 == 47.1	11/17/25 19:55 == 47.2	11/18/25 0:25 == 47.2	11/18/25 4:55 == 47.3

Pumpback Station Discharge (0364)

11/18/25 5:00 == 47.3	11/18/25 9:30 == 47.2	11/18/25 14:00 == 47.3	11/18/25 18:30 == 47
11/18/25 5:05 == 47.2	11/18/25 9:35 == 47.2	11/18/25 14:05 == 47.1	11/18/25 18:35 == 47.2
11/18/25 5:10 == 47.3	11/18/25 9:40 == 47.2	11/18/25 14:10 == 47.1	11/18/25 18:40 == 47.2
11/18/25 5:15 == 47.3	11/18/25 9:45 == 47.2	11/18/25 14:15 == 47.1	11/18/25 18:45 == 47.1
11/18/25 5:20 == 47.3	11/18/25 9:50 == 47.3	11/18/25 14:20 == 47.1	11/18/25 18:50 == 47.1
11/18/25 5:25 == 47.3	11/18/25 9:55 == 47.2	11/18/25 14:25 == 47.2	11/18/25 18:55 == 47.2
11/18/25 5:30 == 47.2	11/18/25 10:00 == 47.2	11/18/25 14:30 == 47.1	11/18/25 19:00 == 47.2
11/18/25 5:35 == 47.2	11/18/25 10:05 == 47.2	11/18/25 14:35 == 47	11/18/25 19:05 == 47.2
11/18/25 5:40 == 47.4	11/18/25 10:10 == 47.2	11/18/25 14:40 == 47.1	11/18/25 19:10 == 47.1
11/18/25 5:45 == 47.4	11/18/25 10:15 == 47.3	11/18/25 14:45 == 47.1	11/18/25 19:15 == 47.1
11/18/25 5:50 == 47.2	11/18/25 10:20 == 47.2	11/18/25 14:50 == 47.1	11/18/25 19:20 == 47.1
11/18/25 5:55 == 47.2	11/18/25 10:25 == 47.2	11/18/25 14:55 == 47.3	11/18/25 19:25 == 47.1
11/18/25 6:00 == 47.2	11/18/25 10:30 == 47.4	11/18/25 15:00 == 47.2	11/18/25 19:30 == 47.4
11/18/25 6:05 == 47	11/18/25 10:35 == 47.2	11/18/25 15:05 == 47.3	11/18/25 19:35 == 47.3
11/18/25 6:10 == 47.4	11/18/25 10:40 == 47.2	11/18/25 15:10 == 47.2	11/18/25 19:40 == 47.1
11/18/25 6:15 == 47.3	11/18/25 10:45 == 47.3	11/18/25 15:15 == 47.2	11/18/25 19:45 == 47.1
11/18/25 6:20 == 47.2	11/18/25 10:50 == 47.1	11/18/25 15:20 == 47.2	11/18/25 19:50 == 47.1
11/18/25 6:25 == 47.2	11/18/25 10:55 == 47.1	11/18/25 15:25 == 47.1	11/18/25 19:55 == 47.2
11/18/25 6:30 == 47.2	11/18/25 11:00 == 47.2	11/18/25 15:30 == 47.2	11/18/25 20:00 == 47.2
11/18/25 6:35 == 47.3	11/18/25 11:05 == 47.2	11/18/25 15:35 == 47.2	11/18/25 20:05 == 47.3
11/18/25 6:40 == 47.4	11/18/25 11:10 == 47.1	11/18/25 15:40 == 47.3	11/18/25 20:10 == 47.1
11/18/25 6:45 == 47.3	11/18/25 11:15 == 47.3	11/18/25 15:45 == 47.3	11/18/25 20:15 == 47.1
11/18/25 6:50 == 47.3	11/18/25 11:20 == 47.5	11/18/25 15:50 == 47.2	11/18/25 20:20 == 47.2
11/18/25 6:55 == 47.2	11/18/25 11:25 == 47.3	11/18/25 15:55 == 47.1	11/18/25 20:25 == 47.2
11/18/25 7:00 == 47.2	11/18/25 11:30 == 47.2	11/18/25 16:00 == 47.3	11/18/25 20:30 == 47.2
11/18/25 7:05 == 47.3	11/18/25 11:35 == 47.1	11/18/25 16:05 == 47.3	11/18/25 20:35 == 47.2
11/18/25 7:10 == 47.2	11/18/25 11:40 == 47.3	11/18/25 16:10 == 47.3	11/18/25 20:40 == 47
11/18/25 7:15 == 47.2	11/18/25 11:45 == 47.2	11/18/25 16:15 == 47.1	11/18/25 20:45 == 47.2
11/18/25 7:20 == 47.1	11/18/25 11:50 == 47.2	11/18/25 16:20 == 47.2	11/18/25 20:50 == 47.1
11/18/25 7:25 == 47.1	11/18/25 11:55 == 47.2	11/18/25 16:25 == 47.3	11/18/25 20:55 == 47.2
11/18/25 7:30 == 47.1	11/18/25 12:00 == 47.2	11/18/25 16:30 == 47.2	11/18/25 21:00 == 47.2
11/18/25 7:35 == 47.2	11/18/25 12:05 == 47.1	11/18/25 16:35 == 47.2	11/18/25 21:05 == 47.2
11/18/25 7:40 == 47.2	11/18/25 12:10 == 47.2	11/18/25 16:40 == 47.1	11/18/25 21:10 == 47.3
11/18/25 7:45 == 47.2	11/18/25 12:15 == 47.3	11/18/25 16:45 == 47	11/18/25 21:15 == 47.2
11/18/25 7:50 == 47.2	11/18/25 12:20 == 47.1	11/18/25 16:50 == 47	11/18/25 21:20 == 47.1
11/18/25 7:55 == 47.3	11/18/25 12:25 == 47.2	11/18/25 16:55 == 47.1	11/18/25 21:25 == 47.1
11/18/25 8:00 == 47.3	11/18/25 12:30 == 47.2	11/18/25 17:00 == 47.1	11/18/25 21:30 == 47.1
11/18/25 8:05 == 47.3	11/18/25 12:35 == 47.4	11/18/25 17:05 == 47.2	11/18/25 21:35 == 47.2
11/18/25 8:10 == 47.3	11/18/25 12:40 == 47.3	11/18/25 17:10 == 47.2	11/18/25 21:40 == 47.2
11/18/25 8:15 == 47.3	11/18/25 12:45 == 47.2	11/18/25 17:15 == 47.1	11/18/25 21:45 == 47.1
11/18/25 8:20 == 47.3	11/18/25 12:50 == 47.2	11/18/25 17:20 == 47	11/18/25 21:50 == 47
11/18/25 8:25 == 47.2	11/18/25 12:55 == 47.2	11/18/25 17:25 == 47.1	11/18/25 21:55 == 47.1
11/18/25 8:30 == 47.3	11/18/25 13:00 == 47.4	11/18/25 17:30 == 47.2	11/18/25 22:00 == 47
11/18/25 8:35 == 47.1	11/18/25 13:05 == 47.2	11/18/25 17:35 == 47.2	11/18/25 22:05 == 47.1
11/18/25 8:40 == 47.1	11/18/25 13:10 == 47.2	11/18/25 17:40 == 47.2	11/18/25 22:10 == 47.1
11/18/25 8:45 == 47.1	11/18/25 13:15 == 47.1	11/18/25 17:45 == 47.4	11/18/25 22:15 == 47.2
11/18/25 8:50 == 47.3	11/18/25 13:20 == 47.2	11/18/25 17:50 == 47.1	11/18/25 22:20 == 47
11/18/25 8:55 == 47.2	11/18/25 13:25 == 47.2	11/18/25 17:55 == 47.3	11/18/25 22:25 == 47.2
11/18/25 9:00 == 47.1	11/18/25 13:30 == 47.2	11/18/25 18:00 == 47.3	11/18/25 22:30 == 47.3
11/18/25 9:05 == 47.2	11/18/25 13:35 == 47.2	11/18/25 18:05 == 47	11/18/25 22:35 == 47.1
11/18/25 9:10 == 47.3	11/18/25 13:40 == 47.1	11/18/25 18:10 == 47.2	11/18/25 22:40 == 47.3
11/18/25 9:15 == 47.3	11/18/25 13:45 == 47.1	11/18/25 18:15 == 47.2	11/18/25 22:45 == 47.2
11/18/25 9:20 == 47.3	11/18/25 13:50 == 47.2	11/18/25 18:20 == 47.2	11/18/25 22:50 == 47.3
11/18/25 9:25 == 47.2	11/18/25 13:55 == 47.4	11/18/25 18:25 == 47.2	11/18/25 22:55 == 47.2

Pumpback Station Discharge (0364)

11/18/25 23:00 == 47.1	11/19/25 3:30 == 47.1	11/19/25 8:00 == 47.2	11/19/25 12:30 == 47.1
11/18/25 23:05 == 47.1	11/19/25 3:35 == 47.1	11/19/25 8:05 == 47.1	11/19/25 12:35 == 46.9
11/18/25 23:10 == 47.1	11/19/25 3:40 == 47.2	11/19/25 8:10 == 46.9	11/19/25 12:40 == 46.9
11/18/25 23:15 == 47.2	11/19/25 3:45 == 47.2	11/19/25 8:15 == 47.1	11/19/25 12:45 == 47.1
11/18/25 23:20 == 47.1	11/19/25 3:50 == 47.1	11/19/25 8:20 == 47.2	11/19/25 12:50 == 47
11/18/25 23:25 == 47.2	11/19/25 3:55 == 47.1	11/19/25 8:25 == 47.2	11/19/25 12:55 == 47
11/18/25 23:30 == 47.2	11/19/25 4:00 == 47.2	11/19/25 8:30 == 47.1	11/19/25 13:00 == 47.1
11/18/25 23:35 == 47.1	11/19/25 4:05 == 47.3	11/19/25 8:35 == 47.1	11/19/25 13:05 == 47
11/18/25 23:40 == 47.2	11/19/25 4:10 == 47.1	11/19/25 8:40 == 47.1	11/19/25 13:10 == 47
11/18/25 23:45 == 47.1	11/19/25 4:15 == 47.1	11/19/25 8:45 == 47	11/19/25 13:15 == 47.1
11/18/25 23:50 == 47.1	11/19/25 4:20 == 47.1	11/19/25 8:50 == 47	11/19/25 13:20 == 47.1
11/18/25 23:55 == 47.2	11/19/25 4:25 == 47.2	11/19/25 8:55 == 47.1	11/19/25 13:25 == 47.2
11/19/25 0:00 == 47.2	11/19/25 4:30 == 47.1	11/19/25 9:00 == 47.1	11/19/25 13:30 == 47.1
11/19/25 0:05 == 47.2	11/19/25 4:35 == 47.1	11/19/25 9:05 == 47	11/19/25 13:35 == 47
11/19/25 0:10 == 47.2	11/19/25 4:40 == 47.2	11/19/25 9:10 == 47.1	11/19/25 13:40 == 47
11/19/25 0:15 == 47.3	11/19/25 4:45 == 47.3	11/19/25 9:15 == 47.1	11/19/25 13:45 == 47.1
11/19/25 0:20 == 47.1	11/19/25 4:50 == 47.3	11/19/25 9:20 == 47.1	11/19/25 13:50 == 47
11/19/25 0:25 == 47.2	11/19/25 4:55 == 47.2	11/19/25 9:25 == 47.2	11/19/25 13:55 == 46.9
11/19/25 0:30 == 47.1	11/19/25 5:00 == 47.1	11/19/25 9:30 == 47.2	11/19/25 14:00 == 46.8
11/19/25 0:35 == 47.3	11/19/25 5:05 == 47.2	11/19/25 9:35 == 47.2	11/19/25 14:05 == 46.9
11/19/25 0:40 == 47	11/19/25 5:10 == 47.2	11/19/25 9:40 == 47.1	11/19/25 14:10 == 47
11/19/25 0:45 == 47.3	11/19/25 5:15 == 47.2	11/19/25 9:45 == 47.2	11/19/25 14:15 == 47
11/19/25 0:50 == 47	11/19/25 5:20 == 47.2	11/19/25 9:50 == 47	11/19/25 14:20 == 47.1
11/19/25 0:55 == 47	11/19/25 5:25 == 47	11/19/25 9:55 == 47.3	11/19/25 14:25 == 47.1
11/19/25 1:00 == 47	11/19/25 5:30 == 47.1	11/19/25 10:00 == 47.2	11/19/25 14:30 == 47
11/19/25 1:05 == 47.1	11/19/25 5:35 == 46.9	11/19/25 10:05 == 47.1	11/19/25 14:35 == 47
11/19/25 1:10 == 47.2	11/19/25 5:40 == 47	11/19/25 10:10 == 47.1	11/19/25 14:40 == 47
11/19/25 1:15 == 47.1	11/19/25 5:45 == 47.2	11/19/25 10:15 == 46.9	11/19/25 14:45 == 47
11/19/25 1:20 == 46.9	11/19/25 5:50 == 47.1	11/19/25 10:20 == 47.1	11/19/25 14:50 == 47.1
11/19/25 1:25 == 47.1	11/19/25 5:55 == 46.9	11/19/25 10:25 == 47	11/19/25 14:55 == 47.2
11/19/25 1:30 == 47.3	11/19/25 6:00 == 47.2	11/19/25 10:30 == 47	11/19/25 15:00 == 47
11/19/25 1:35 == 47.2	11/19/25 6:05 == 47.1	11/19/25 10:35 == 47	11/19/25 15:05 == 47.1
11/19/25 1:40 == 47.1	11/19/25 6:10 == 47.1	11/19/25 10:40 == 47	11/19/25 15:10 == 47.1
11/19/25 1:45 == 47.2	11/19/25 6:15 == 47.2	11/19/25 10:45 == 47	11/19/25 15:15 == 46.9
11/19/25 1:50 == 47.1	11/19/25 6:20 == 47.2	11/19/25 10:50 == 47	11/19/25 15:20 == 47
11/19/25 1:55 == 47.1	11/19/25 6:25 == 47.1	11/19/25 10:55 == 47.1	11/19/25 15:25 == 46.9
11/19/25 2:00 == 47.1	11/19/25 6:30 == 47.2	11/19/25 11:00 == 47.1	11/19/25 15:30 == 46.8
11/19/25 2:05 == 47	11/19/25 6:35 == 47.2	11/19/25 11:05 == 47	11/19/25 15:35 == 47
11/19/25 2:10 == 47	11/19/25 6:40 == 47.1	11/19/25 11:10 == 47	11/19/25 15:40 == 47.2
11/19/25 2:15 == 47.2	11/19/25 6:45 == 47.1	11/19/25 11:15 == 47	11/19/25 15:45 == 47.2
11/19/25 2:20 == 47.1	11/19/25 6:50 == 47	11/19/25 11:20 == 47	11/19/25 15:50 == 47
11/19/25 2:25 == 47.2	11/19/25 6:55 == 47	11/19/25 11:25 == 47.1	11/19/25 15:55 == 46.9
11/19/25 2:30 == 47.1	11/19/25 7:00 == 47.1	11/19/25 11:30 == 47.1	11/19/25 16:00 == 47
11/19/25 2:35 == 47	11/19/25 7:05 == 47.3	11/19/25 11:35 == 46.9	11/19/25 16:05 == 47
11/19/25 2:40 == 47.1	11/19/25 7:10 == 47.4	11/19/25 11:40 == 46.9	11/19/25 16:10 == 47
11/19/25 2:45 == 47	11/19/25 7:15 == 47.1	11/19/25 11:45 == 46.9	11/19/25 16:15 == 47.1
11/19/25 2:50 == 46.8	11/19/25 7:20 == 47.2	11/19/25 11:50 == 47.1	11/19/25 16:20 == 47
11/19/25 2:55 == 47.1	11/19/25 7:25 == 47.1	11/19/25 11:55 == 47.1	11/19/25 16:25 == 47
11/19/25 3:00 == 47	11/19/25 7:30 == 47.1	11/19/25 12:00 == 46.8	11/19/25 16:30 == 47.1
11/19/25 3:05 == 47.3	11/19/25 7:35 == 47.2	11/19/25 12:05 == 47	11/19/25 16:35 == 47
11/19/25 3:10 == 47	11/19/25 7:40 == 47.2	11/19/25 12:10 == 47	11/19/25 16:40 == 47
11/19/25 3:15 == 47	11/19/25 7:45 == 47	11/19/25 12:15 == 47.1	11/19/25 16:45 == 47
11/19/25 3:20 == 47	11/19/25 7:50 == 47.2	11/19/25 12:20 == 47.1	11/19/25 16:50 == 46.9
11/19/25 3:25 == 47	11/19/25 7:55 == 47.1	11/19/25 12:25 == 46.8	11/19/25 16:55 == 47.2

Pumpback Station Discharge (0364)

11/19/25 17:00 == 47.1	11/19/25 21:30 == 47.1	11/20/25 2:00 == 47	11/20/25 6:30 == 47
11/19/25 17:05 == 46.9	11/19/25 21:35 == 46.9	11/20/25 2:05 == 47	11/20/25 6:35 == 47.1
11/19/25 17:10 == 46.9	11/19/25 21:40 == 46.9	11/20/25 2:10 == 47	11/20/25 6:40 == 46.9
11/19/25 17:15 == 47	11/19/25 21:45 == 47	11/20/25 2:15 == 47.1	11/20/25 6:45 == 47.1
11/19/25 17:20 == 47.1	11/19/25 21:50 == 46.9	11/20/25 2:20 == 46.9	11/20/25 6:50 == 47.3
11/19/25 17:25 == 47	11/19/25 21:55 == 47	11/20/25 2:25 == 47	11/20/25 6:55 == 47.1
11/19/25 17:30 == 47	11/19/25 22:00 == 46.9	11/20/25 2:30 == 47.2	11/20/25 7:00 == 47.2
11/19/25 17:35 == 47.1	11/19/25 22:05 == 47.1	11/20/25 2:35 == 47.1	11/20/25 7:05 == 47.1
11/19/25 17:40 == 47.3	11/19/25 22:10 == 46.8	11/20/25 2:40 == 47.2	11/20/25 7:10 == 47.1
11/19/25 17:45 == 47	11/19/25 22:15 == 47.2	11/20/25 2:45 == 47.1	11/20/25 7:15 == 46.9
11/19/25 17:50 == 46.9	11/19/25 22:20 == 47.1	11/20/25 2:50 == 47	11/20/25 7:20 == 47.1
11/19/25 17:55 == 47.1	11/19/25 22:25 == 47	11/20/25 2:55 == 47.1	11/20/25 7:25 == 46.9
11/19/25 18:00 == 47.2	11/19/25 22:30 == 47	11/20/25 3:00 == 47.1	11/20/25 7:30 == 47
11/19/25 18:05 == 47.1	11/19/25 22:35 == 47	11/20/25 3:05 == 47	11/20/25 7:35 == 47.2
11/19/25 18:10 == 47	11/19/25 22:40 == 46.9	11/20/25 3:10 == 47	11/20/25 7:40 == 47
11/19/25 18:15 == 46.8	11/19/25 22:45 == 47	11/20/25 3:15 == 47	11/20/25 7:45 == 47
11/19/25 18:20 == 46.9	11/19/25 22:50 == 47.1	11/20/25 3:20 == 47	11/20/25 7:50 == 47
11/19/25 18:25 == 47	11/19/25 22:55 == 47	11/20/25 3:25 == 47.1	11/20/25 7:55 == 47.1
11/19/25 18:30 == 46.9	11/19/25 23:00 == 47	11/20/25 3:30 == 47	11/20/25 8:00 == 47.2
11/19/25 18:35 == 47	11/19/25 23:05 == 46.9	11/20/25 3:35 == 47.1	11/20/25 8:05 == 47.1
11/19/25 18:40 == 46.9	11/19/25 23:10 == 46.9	11/20/25 3:40 == 47.2	11/20/25 8:10 == 47
11/19/25 18:45 == 46.9	11/19/25 23:15 == 47	11/20/25 3:45 == 47.2	11/20/25 8:15 == 47
11/19/25 18:50 == 47.2	11/19/25 23:20 == 47.1	11/20/25 3:50 == 47.1	11/20/25 8:20 == 47.1
11/19/25 18:55 == 47	11/19/25 23:25 == 46.9	11/20/25 3:55 == 47	11/20/25 8:25 == 47.1
11/19/25 19:00 == 47	11/19/25 23:30 == 46.9	11/20/25 4:00 == 47.2	11/20/25 8:30 == 47
11/19/25 19:05 == 47	11/19/25 23:35 == 47	11/20/25 4:05 == 47.1	11/20/25 8:35 == 47
11/19/25 19:10 == 46.8	11/19/25 23:40 == 47	11/20/25 4:10 == 47.2	11/20/25 8:40 == 47.1
11/19/25 19:15 == 46.9	11/19/25 23:45 == 47	11/20/25 4:15 == 47.1	11/20/25 8:45 == 47.1
11/19/25 19:20 == 47	11/19/25 23:50 == 47.1	11/20/25 4:20 == 47	11/20/25 8:50 == 47.1
11/19/25 19:25 == 46.9	11/19/25 23:55 == 46.9	11/20/25 4:25 == 47	11/20/25 8:55 == 47
11/19/25 19:30 == 47.2	11/20/25 0:00 == 46.8	11/20/25 4:30 == 47	11/20/25 9:00 == 47.1
11/19/25 19:35 == 47.1	11/20/25 0:05 == 47.1	11/20/25 4:35 == 47.1	11/20/25 9:05 == 47
11/19/25 19:40 == 47.1	11/20/25 0:10 == 46.8	11/20/25 4:40 == 47.2	11/20/25 9:10 == 46.9
11/19/25 19:45 == 47	11/20/25 0:15 == 47	11/20/25 4:45 == 46.9	11/20/25 9:15 == 47.1
11/19/25 19:50 == 47	11/20/25 0:20 == 46.9	11/20/25 4:50 == 47.2	11/20/25 9:20 == 47.2
11/19/25 19:55 == 47	11/20/25 0:25 == 46.9	11/20/25 4:55 == 46.9	11/20/25 9:25 == 47.1
11/19/25 20:00 == 47	11/20/25 0:30 == 47	11/20/25 5:00 == 47	11/20/25 9:30 == 47.1
11/19/25 20:05 == 47.1	11/20/25 0:35 == 47	11/20/25 5:05 == 47.1	11/20/25 9:35 == 47.2
11/19/25 20:10 == 47	11/20/25 0:40 == 47	11/20/25 5:10 == 47	11/20/25 9:40 == 47
11/19/25 20:15 == 47	11/20/25 0:45 == 47.1	11/20/25 5:15 == 47	11/20/25 9:45 == 47
11/19/25 20:20 == 47	11/20/25 0:50 == 47	11/20/25 5:20 == 47	11/20/25 9:50 == 47
11/19/25 20:25 == 47	11/20/25 0:55 == 47	11/20/25 5:25 == 47.2	11/20/25 9:55 == 47.1
11/19/25 20:30 == 47	11/20/25 1:00 == 47	11/20/25 5:30 == 47.2	11/20/25 10:00 == 47
11/19/25 20:35 == 47.1	11/20/25 1:05 == 46.9	11/20/25 5:35 == 47.1	11/20/25 10:05 == 47.1
11/19/25 20:40 == 47.1	11/20/25 1:10 == 47	11/20/25 5:40 == 47	11/20/25 10:10 == 47.1
11/19/25 20:45 == 46.8	11/20/25 1:15 == 47.1	11/20/25 5:45 == 47.1	11/20/25 10:15 == 47
11/19/25 20:50 == 46.9	11/20/25 1:20 == 47.1	11/20/25 5:50 == 47.2	11/20/25 10:20 == 46.9
11/19/25 20:55 == 47	11/20/25 1:25 == 47	11/20/25 5:55 == 47.2	11/20/25 10:25 == 47
11/19/25 21:00 == 46.9	11/20/25 1:30 == 47	11/20/25 6:00 == 47.1	11/20/25 10:30 == 47.1
11/19/25 21:05 == 46.9	11/20/25 1:35 == 46.9	11/20/25 6:05 == 47.1	11/20/25 10:35 == 47
11/19/25 21:10 == 47	11/20/25 1:40 == 47	11/20/25 6:10 == 47.1	11/20/25 10:40 == 47
11/19/25 21:15 == 46.9	11/20/25 1:45 == 46.9	11/20/25 6:15 == 47.2	11/20/25 10:45 == 47
11/19/25 21:20 == 47	11/20/25 1:50 == 46.9	11/20/25 6:20 == 47.1	11/20/25 10:50 == 46.9
11/19/25 21:25 == 47	11/20/25 1:55 == 47	11/20/25 6:25 == 47	11/20/25 10:55 == 47

Pumpback Station Discharge (0364)

11/20/25 11:00 == 47.1	11/20/25 15:30 == 47.1	11/20/25 20:00 == 47	11/21/25 0:30 == 47.1
11/20/25 11:05 == 47	11/20/25 15:35 == 47.1	11/20/25 20:05 == 47	11/21/25 0:35 == 47
11/20/25 11:10 == 47.1	11/20/25 15:40 == 47	11/20/25 20:10 == 47.1	11/21/25 0:40 == 46.9
11/20/25 11:15 == 47.1	11/20/25 15:45 == 47	11/20/25 20:15 == 47.1	11/21/25 0:45 == 46.8
11/20/25 11:20 == 47.1	11/20/25 15:50 == 47	11/20/25 20:20 == 47.1	11/21/25 0:50 == 47.1
11/20/25 11:25 == 47.1	11/20/25 15:55 == 47	11/20/25 20:25 == 47.1	11/21/25 0:55 == 47.1
11/20/25 11:30 == 47.1	11/20/25 16:00 == 47.1	11/20/25 20:30 == 47	11/21/25 1:00 == 47.2
11/20/25 11:35 == 46.9	11/20/25 16:05 == 47.1	11/20/25 20:35 == 47	11/21/25 1:05 == 47.1
11/20/25 11:40 == 47.2	11/20/25 16:10 == 47.1	11/20/25 20:40 == 47	11/21/25 1:10 == 47.2
11/20/25 11:45 == 46.9	11/20/25 16:15 == 47.1	11/20/25 20:45 == 46.9	11/21/25 1:15 == 47.1
11/20/25 11:50 == 46.9	11/20/25 16:20 == 47.2	11/20/25 20:50 == 47.1	11/21/25 1:20 == 47.1
11/20/25 11:55 == 47.2	11/20/25 16:25 == 47.2	11/20/25 20:55 == 46.9	11/21/25 1:25 == 47.2
11/20/25 12:00 == 47.1	11/20/25 16:30 == 47.1	11/20/25 21:00 == 47.1	11/21/25 1:30 == 47.2
11/20/25 12:05 == 47.1	11/20/25 16:35 == 47.1	11/20/25 21:05 == 47.1	11/21/25 1:35 == 47
11/20/25 12:10 == 47.1	11/20/25 16:40 == 47	11/20/25 21:10 == 47.1	11/21/25 1:40 == 47.1
11/20/25 12:15 == 47.1	11/20/25 16:45 == 47	11/20/25 21:15 == 47	11/21/25 1:45 == 47.1
11/20/25 12:20 == 47.2	11/20/25 16:50 == 47	11/20/25 21:20 == 47.2	11/21/25 1:50 == 47.2
11/20/25 12:25 == 47.1	11/20/25 16:55 == 47.1	11/20/25 21:25 == 47.1	11/21/25 1:55 == 47.1
11/20/25 12:30 == 47.1	11/20/25 17:00 == 47	11/20/25 21:30 == 47.1	11/21/25 2:00 == 47
11/20/25 12:35 == 47.1	11/20/25 17:05 == 47.1	11/20/25 21:35 == 47	11/21/25 2:05 == 47.1
11/20/25 12:40 == 47.2	11/20/25 17:10 == 47	11/20/25 21:40 == 47	11/21/25 2:10 == 47.2
11/20/25 12:45 == 47.2	11/20/25 17:15 == 46.9	11/20/25 21:45 == 47	11/21/25 2:15 == 47.1
11/20/25 12:50 == 47.2	11/20/25 17:20 == 47	11/20/25 21:50 == 47	11/21/25 2:20 == 47
11/20/25 12:55 == 47.2	11/20/25 17:25 == 47	11/20/25 21:55 == 47.1	11/21/25 2:25 == 47.1
11/20/25 13:00 == 47.2	11/20/25 17:30 == 47	11/20/25 22:00 == 47	11/21/25 2:30 == 47.2
11/20/25 13:05 == 47	11/20/25 17:35 == 47.1	11/20/25 22:05 == 47	11/21/25 2:35 == 47.1
11/20/25 13:10 == 47.1	11/20/25 17:40 == 47.1	11/20/25 22:10 == 47	11/21/25 2:40 == 47
11/20/25 13:15 == 47.2	11/20/25 17:45 == 47	11/20/25 22:15 == 47	11/21/25 2:45 == 47
11/20/25 13:20 == 47.1	11/20/25 17:50 == 47	11/20/25 22:20 == 47	11/21/25 2:50 == 47.1
11/20/25 13:25 == 47.1	11/20/25 17:55 == 47	11/20/25 22:25 == 47	11/21/25 2:55 == 47.1
11/20/25 13:30 == 47.1	11/20/25 18:00 == 47.1	11/20/25 22:30 == 47	11/21/25 3:00 == 47.1
11/20/25 13:35 == 46.8	11/20/25 18:05 == 47	11/20/25 22:35 == 47	11/21/25 3:05 == 47
11/20/25 13:40 == 46.8	11/20/25 18:10 == 46.9	11/20/25 22:40 == 47	11/21/25 3:10 == 47.1
11/20/25 13:45 == 47	11/20/25 18:15 == 47.1	11/20/25 22:45 == 47.1	11/21/25 3:15 == 47.1
11/20/25 13:50 == 47.1	11/20/25 18:20 == 47.2	11/20/25 22:50 == 47.1	11/21/25 3:20 == 47
11/20/25 13:55 == 46.9	11/20/25 18:25 == 47.2	11/20/25 22:55 == 47	11/21/25 3:25 == 47
11/20/25 14:00 == 47.1	11/20/25 18:30 == 47.2	11/20/25 23:00 == 47	11/21/25 3:30 == 47.2
11/20/25 14:05 == 47.2	11/20/25 18:35 == 46.9	11/20/25 23:05 == 47.1	11/21/25 3:35 == 46.9
11/20/25 14:10 == 47.1	11/20/25 18:40 == 47.1	11/20/25 23:10 == 46.9	11/21/25 3:40 == 47
11/20/25 14:15 == 47.2	11/20/25 18:45 == 46.9	11/20/25 23:15 == 46.9	11/21/25 3:45 == 47.1
11/20/25 14:20 == 47	11/20/25 18:50 == 46.8	11/20/25 23:20 == 47.1	11/21/25 3:50 == 47
11/20/25 14:25 == 47.1	11/20/25 18:55 == 46.9	11/20/25 23:25 == 47.2	11/21/25 3:55 == 47.3
11/20/25 14:30 == 47	11/20/25 19:00 == 46.9	11/20/25 23:30 == 47	11/21/25 4:00 == 47.1
11/20/25 14:35 == 47.1	11/20/25 19:05 == 47.1	11/20/25 23:35 == 47.1	11/21/25 4:05 == 47
11/20/25 14:40 == 47.1	11/20/25 19:10 == 47	11/20/25 23:40 == 47	11/21/25 4:10 == 47
11/20/25 14:45 == 47	11/20/25 19:15 == 47	11/20/25 23:45 == 47	11/21/25 4:15 == 47.2
11/20/25 14:50 == 46.9	11/20/25 19:20 == 47	11/20/25 23:50 == 46.9	11/21/25 4:20 == 47.2
11/20/25 14:55 == 47	11/20/25 19:25 == 47.1	11/20/25 23:55 == 47	11/21/25 4:25 == 47.2
11/20/25 15:00 == 47.1	11/20/25 19:30 == 47.1	11/21/25 0:00 == 47	11/21/25 4:30 == 47.3
11/20/25 15:05 == 47.1	11/20/25 19:35 == 47	11/21/25 0:05 == 46.9	11/21/25 4:35 == 47
11/20/25 15:10 == 47.1	11/20/25 19:40 == 47	11/21/25 0:10 == 46.9	11/21/25 4:40 == 47.1
11/20/25 15:15 == 47.2	11/20/25 19:45 == 47	11/21/25 0:15 == 47	11/21/25 4:45 == 47.1
11/20/25 15:20 == 47.1	11/20/25 19:50 == 47	11/21/25 0:20 == 47.1	11/21/25 4:50 == 47.1
11/20/25 15:25 == 47	11/20/25 19:55 == 47	11/21/25 0:25 == 47.1	11/21/25 4:55 == 47.1

Pumpback Station Discharge (0364)

11/21/25 5:00 == 47.1	11/21/25 9:30 == 47.1	11/21/25 14:00 == 47.1	11/21/25 18:30 == 47
11/21/25 5:05 == 47.1	11/21/25 9:35 == 47.1	11/21/25 14:05 == 47	11/21/25 18:35 == 47.2
11/21/25 5:10 == 47.2	11/21/25 9:40 == 47.1	11/21/25 14:10 == 47	11/21/25 18:40 == 47.1
11/21/25 5:15 == 47.1	11/21/25 9:45 == 47.1	11/21/25 14:15 == 47	11/21/25 18:45 == 47.1
11/21/25 5:20 == 47	11/21/25 9:50 == 47.1	11/21/25 14:20 == 47	11/21/25 18:50 == 47.1
11/21/25 5:25 == 47	11/21/25 9:55 == 47.1	11/21/25 14:25 == 47	11/21/25 18:55 == 47.1
11/21/25 5:30 == 47	11/21/25 10:00 == 47.1	11/21/25 14:30 == 47.1	11/21/25 19:00 == 47
11/21/25 5:35 == 47	11/21/25 10:05 == 46.9	11/21/25 14:35 == 47.2	11/21/25 19:05 == 47.1
11/21/25 5:40 == 47.1	11/21/25 10:10 == 47	11/21/25 14:40 == 47	11/21/25 19:10 == 47.1
11/21/25 5:45 == 47.2	11/21/25 10:15 == 47.2	11/21/25 14:45 == 47.1	11/21/25 19:15 == 46.9
11/21/25 5:50 == 47	11/21/25 10:20 == 47	11/21/25 14:50 == 47	11/21/25 19:20 == 46.9
11/21/25 5:55 == 47.1	11/21/25 10:25 == 47.1	11/21/25 14:55 == 47	11/21/25 19:25 == 46.9
11/21/25 6:00 == 47	11/21/25 10:30 == 47.1	11/21/25 15:00 == 47	11/21/25 19:30 == 47
11/21/25 6:05 == 47.1	11/21/25 10:35 == 47.1	11/21/25 15:05 == 47	11/21/25 19:35 == 47
11/21/25 6:10 == 47	11/21/25 10:40 == 47	11/21/25 15:10 == 47	11/21/25 19:40 == 47.1
11/21/25 6:15 == 47	11/21/25 10:45 == 47.1	11/21/25 15:15 == 47.2	11/21/25 19:45 == 47.1
11/21/25 6:20 == 47.2	11/21/25 10:50 == 47.2	11/21/25 15:20 == 46.8	11/21/25 19:50 == 46.9
11/21/25 6:25 == 47.1	11/21/25 10:55 == 47.2	11/21/25 15:25 == 47	11/21/25 19:55 == 47
11/21/25 6:30 == 47.1	11/21/25 11:00 == 47	11/21/25 15:30 == 46.9	11/21/25 20:00 == 47.1
11/21/25 6:35 == 47.1	11/21/25 11:05 == 46.9	11/21/25 15:35 == 47	11/21/25 20:05 == 46.9
11/21/25 6:40 == 47.1	11/21/25 11:10 == 47.1	11/21/25 15:40 == 47.1	11/21/25 20:10 == 47
11/21/25 6:45 == 47	11/21/25 11:15 == 47.2	11/21/25 15:45 == 47.1	11/21/25 20:15 == 47
11/21/25 6:50 == 47	11/21/25 11:20 == 47.1	11/21/25 15:50 == 47	11/21/25 20:20 == 47.1
11/21/25 6:55 == 47	11/21/25 11:25 == 47.1	11/21/25 15:55 == 47.1	11/21/25 20:25 == 47
11/21/25 7:00 == 47.2	11/21/25 11:30 == 47.1	11/21/25 16:00 == 47	11/21/25 20:30 == 47
11/21/25 7:05 == 47.2	11/21/25 11:35 == 47	11/21/25 16:05 == 47	11/21/25 20:35 == 47
11/21/25 7:10 == 47	11/21/25 11:40 == 47	11/21/25 16:10 == 47	11/21/25 20:40 == 47.1
11/21/25 7:15 == 47	11/21/25 11:45 == 47.1	11/21/25 16:15 == 47.1	11/21/25 20:45 == 47.1
11/21/25 7:20 == 47.1	11/21/25 11:50 == 47	11/21/25 16:20 == 47	11/21/25 20:50 == 47
11/21/25 7:25 == 47.1	11/21/25 11:55 == 47	11/21/25 16:25 == 47	11/21/25 20:55 == 46.9
11/21/25 7:30 == 47.1	11/21/25 12:00 == 46.9	11/21/25 16:30 == 47	11/21/25 21:00 == 47
11/21/25 7:35 == 47.1	11/21/25 12:05 == 46.8	11/21/25 16:35 == 46.9	11/21/25 21:05 == 47.1
11/21/25 7:40 == 47.2	11/21/25 12:10 == 46.9	11/21/25 16:40 == 47	11/21/25 21:10 == 47
11/21/25 7:45 == 47.1	11/21/25 12:15 == 47	11/21/25 16:45 == 47	11/21/25 21:15 == 46.9
11/21/25 7:50 == 47.1	11/21/25 12:20 == 47	11/21/25 16:50 == 47	11/21/25 21:20 == 46.9
11/21/25 7:55 == 47.1	11/21/25 12:25 == 47	11/21/25 16:55 == 47.1	11/21/25 21:25 == 47
11/21/25 8:00 == 47.1	11/21/25 12:30 == 47.1	11/21/25 17:00 == 46.9	11/21/25 21:30 == 47.1
11/21/25 8:05 == 46.9	11/21/25 12:35 == 47	11/21/25 17:05 == 47	11/21/25 21:35 == 47
11/21/25 8:10 == 47.1	11/21/25 12:40 == 47	11/21/25 17:10 == 47	11/21/25 21:40 == 47
11/21/25 8:15 == 47.2	11/21/25 12:45 == 47.1	11/21/25 17:15 == 46.9	11/21/25 21:45 == 47
11/21/25 8:20 == 46.9	11/21/25 12:50 == 47	11/21/25 17:20 == 47	11/21/25 21:50 == 47
11/21/25 8:25 == 47	11/21/25 12:55 == 47.2	11/21/25 17:25 == 47.1	11/21/25 21:55 == 47.1
11/21/25 8:30 == 46.8	11/21/25 13:00 == 46.9	11/21/25 17:30 == 46.9	11/21/25 22:00 == 47.1
11/21/25 8:35 == 47.1	11/21/25 13:05 == 47.1	11/21/25 17:35 == 47.1	11/21/25 22:05 == 47
11/21/25 8:40 == 46.9	11/21/25 13:10 == 47	11/21/25 17:40 == 47.2	11/21/25 22:10 == 47.1
11/21/25 8:45 == 46.8	11/21/25 13:15 == 46.9	11/21/25 17:45 == 47	11/21/25 22:15 == 47
11/21/25 8:50 == 46.9	11/21/25 13:20 == 47	11/21/25 17:50 == 46.9	11/21/25 22:20 == 47.3
11/21/25 8:55 == 47.1	11/21/25 13:25 == 47.2	11/21/25 17:55 == 47.1	11/21/25 22:25 == 47.3
11/21/25 9:00 == 47.3	11/21/25 13:30 == 47	11/21/25 18:00 == 47	11/21/25 22:30 == 47.1
11/21/25 9:05 == 47.1	11/21/25 13:35 == 47	11/21/25 18:05 == 47	11/21/25 22:35 == 47.2
11/21/25 9:10 == 46.9	11/21/25 13:40 == 46.9	11/21/25 18:10 == 46.9	11/21/25 22:40 == 47.1
11/21/25 9:15 == 47	11/21/25 13:45 == 47.1	11/21/25 18:15 == 47	11/21/25 22:45 == 47.1
11/21/25 9:20 == 47	11/21/25 13:50 == 47	11/21/25 18:20 == 47	11/21/25 22:50 == 46.9
11/21/25 9:25 == 47.1	11/21/25 13:55 == 47	11/21/25 18:25 == 46.9	11/21/25 22:55 == 46.9

Pumpback Station Discharge (0364)

11/21/25 23:00 == 47	11/22/25 3:30 == 47.1	11/22/25 8:00 == 46.9	11/22/25 12:30 == 47.1
11/21/25 23:05 == 47	11/22/25 3:35 == 47.1	11/22/25 8:05 == 46.8	11/22/25 12:35 == 47
11/21/25 23:10 == 47	11/22/25 3:40 == 46.9	11/22/25 8:10 == 46.9	11/22/25 12:40 == 46.8
11/21/25 23:15 == 47.1	11/22/25 3:45 == 47	11/22/25 8:15 == 46.9	11/22/25 12:45 == 46.8
11/21/25 23:20 == 47.1	11/22/25 3:50 == 46.9	11/22/25 8:20 == 47	11/22/25 12:50 == 46.9
11/21/25 23:25 == 47	11/22/25 3:55 == 46.8	11/22/25 8:25 == 47	11/22/25 12:55 == 46.9
11/21/25 23:30 == 47	11/22/25 4:00 == 46.9	11/22/25 8:30 == 47	11/22/25 13:00 == 46.8
11/21/25 23:35 == 47.1	11/22/25 4:05 == 46.9	11/22/25 8:35 == 47	11/22/25 13:05 == 46.8
11/21/25 23:40 == 47.2	11/22/25 4:10 == 46.8	11/22/25 8:40 == 46.9	11/22/25 13:10 == 46.9
11/21/25 23:45 == 47	11/22/25 4:15 == 46.9	11/22/25 8:45 == 46.9	11/22/25 13:15 == 46.9
11/21/25 23:50 == 46.9	11/22/25 4:20 == 46.9	11/22/25 8:50 == 47	11/22/25 13:20 == 46.9
11/21/25 23:55 == 47	11/22/25 4:25 == 47	11/22/25 8:55 == 47	11/22/25 13:25 == 47
11/22/25 0:00 == 47.1	11/22/25 4:30 == 47	11/22/25 9:00 == 46.8	11/22/25 13:30 == 47
11/22/25 0:05 == 47.1	11/22/25 4:35 == 47	11/22/25 9:05 == 46.8	11/22/25 13:35 == 47
11/22/25 0:10 == 46.9	11/22/25 4:40 == 46.8	11/22/25 9:10 == 47	11/22/25 13:40 == 47.1
11/22/25 0:15 == 47	11/22/25 4:45 == 46.9	11/22/25 9:15 == 47	11/22/25 13:45 == 47
11/22/25 0:20 == 47.1	11/22/25 4:50 == 46.8	11/22/25 9:20 == 47.1	11/22/25 13:50 == 47
11/22/25 0:25 == 47	11/22/25 4:55 == 47	11/22/25 9:25 == 46.9	11/22/25 13:55 == 47
11/22/25 0:30 == 47	11/22/25 5:00 == 47.1	11/22/25 9:30 == 47	11/22/25 14:00 == 46.9
11/22/25 0:35 == 47	11/22/25 5:05 == 47	11/22/25 9:35 == 47	11/22/25 14:05 == 46.8
11/22/25 0:40 == 46.8	11/22/25 5:10 == 46.9	11/22/25 9:40 == 47	11/22/25 14:10 == 46.8
11/22/25 0:45 == 46.9	11/22/25 5:15 == 46.9	11/22/25 9:45 == 47.2	11/22/25 14:15 == 46.8
11/22/25 0:50 == 47.1	11/22/25 5:20 == 46.9	11/22/25 9:50 == 46.6	11/22/25 14:20 == 47
11/22/25 0:55 == 46.9	11/22/25 5:25 == 47	11/22/25 9:55 == 46.9	11/22/25 14:25 == 46.8
11/22/25 1:00 == 46.9	11/22/25 5:30 == 46.9	11/22/25 10:00 == 46.8	11/22/25 14:30 == 47
11/22/25 1:05 == 46.9	11/22/25 5:35 == 46.7	11/22/25 10:05 == 46.8	11/22/25 14:35 == 47
11/22/25 1:10 == 46.9	11/22/25 5:40 == 47	11/22/25 10:10 == 47	11/22/25 14:40 == 46.9
11/22/25 1:15 == 47	11/22/25 5:45 == 47	11/22/25 10:15 == 47	11/22/25 14:45 == 46.8
11/22/25 1:20 == 46.9	11/22/25 5:50 == 46.9	11/22/25 10:20 == 47	11/22/25 14:50 == 47
11/22/25 1:25 == 46.9	11/22/25 5:55 == 47	11/22/25 10:25 == 46.9	11/22/25 14:55 == 47
11/22/25 1:30 == 47.1	11/22/25 6:00 == 46.8	11/22/25 10:30 == 46.9	11/22/25 15:00 == 46.9
11/22/25 1:35 == 47.1	11/22/25 6:05 == 46.8	11/22/25 10:35 == 46.8	11/22/25 15:05 == 46.9
11/22/25 1:40 == 46.9	11/22/25 6:10 == 46.9	11/22/25 10:40 == 46.8	11/22/25 15:10 == 47
11/22/25 1:45 == 46.9	11/22/25 6:15 == 46.9	11/22/25 10:45 == 46.9	11/22/25 15:15 == 47
11/22/25 1:50 == 47	11/22/25 6:20 == 46.8	11/22/25 10:50 == 47	11/22/25 15:20 == 47.1
11/22/25 1:55 == 47	11/22/25 6:25 == 46.8	11/22/25 10:55 == 46.9	11/22/25 15:25 == 47
11/22/25 2:00 == 47	11/22/25 6:30 == 46.9	11/22/25 11:00 == 46.9	11/22/25 15:30 == 47
11/22/25 2:05 == 47.2	11/22/25 6:35 == 46.9	11/22/25 11:05 == 47	11/22/25 15:35 == 46.9
11/22/25 2:10 == 47.1	11/22/25 6:40 == 46.9	11/22/25 11:10 == 47	11/22/25 15:40 == 46.9
11/22/25 2:15 == 47.1	11/22/25 6:45 == 46.9	11/22/25 11:15 == 46.9	11/22/25 15:45 == 47
11/22/25 2:20 == 47.1	11/22/25 6:50 == 46.9	11/22/25 11:20 == 46.8	11/22/25 15:50 == 46.9
11/22/25 2:25 == 47.1	11/22/25 6:55 == 47	11/22/25 11:25 == 46.9	11/22/25 15:55 == 46.9
11/22/25 2:30 == 47.1	11/22/25 7:00 == 47.1	11/22/25 11:30 == 46.9	11/22/25 16:00 == 46.9
11/22/25 2:35 == 47.1	11/22/25 7:05 == 47	11/22/25 11:35 == 47	11/22/25 16:05 == 46.9
11/22/25 2:40 == 47.1	11/22/25 7:10 == 47.2	11/22/25 11:40 == 47	11/22/25 16:10 == 47
11/22/25 2:45 == 47.1	11/22/25 7:15 == 47	11/22/25 11:45 == 47	11/22/25 16:15 == 47
11/22/25 2:50 == 47.1	11/22/25 7:20 == 46.8	11/22/25 11:50 == 47	11/22/25 16:20 == 46.9
11/22/25 2:55 == 47.2	11/22/25 7:25 == 46.9	11/22/25 11:55 == 46.8	11/22/25 16:25 == 46.8
11/22/25 3:00 == 47	11/22/25 7:30 == 46.9	11/22/25 12:00 == 46.9	11/22/25 16:30 == 47.1
11/22/25 3:05 == 47	11/22/25 7:35 == 47	11/22/25 12:05 == 47.1	11/22/25 16:35 == 46.9
11/22/25 3:10 == 47	11/22/25 7:40 == 46.9	11/22/25 12:10 == 46.7	11/22/25 16:40 == 46.9
11/22/25 3:15 == 46.9	11/22/25 7:45 == 46.8	11/22/25 12:15 == 46.9	11/22/25 16:45 == 46.8
11/22/25 3:20 == 46.9	11/22/25 7:50 == 46.9	11/22/25 12:20 == 46.9	11/22/25 16:50 == 47.1
11/22/25 3:25 == 46.9	11/22/25 7:55 == 47	11/22/25 12:25 == 47	11/22/25 16:55 == 46.9

Pumpback Station Discharge (0364)

11/22/25 17:00 == 46.9	11/22/25 21:30 == 46.7	11/23/25 2:00 == 46.7	11/23/25 6:30 == 46.9
11/22/25 17:05 == 47	11/22/25 21:35 == 46.8	11/23/25 2:05 == 46.9	11/23/25 6:35 == 46.8
11/22/25 17:10 == 47	11/22/25 21:40 == 46.8	11/23/25 2:10 == 47	11/23/25 6:40 == 46.9
11/22/25 17:15 == 47	11/22/25 21:45 == 46.9	11/23/25 2:15 == 47.1	11/23/25 6:45 == 46.9
11/22/25 17:20 == 47	11/22/25 21:50 == 46.9	11/23/25 2:20 == 47	11/23/25 6:50 == 46.9
11/22/25 17:25 == 46.9	11/22/25 21:55 == 46.9	11/23/25 2:25 == 46.7	11/23/25 6:55 == 47.1
11/22/25 17:30 == 46.7	11/22/25 22:00 == 47	11/23/25 2:30 == 46.9	11/23/25 7:00 == 46.9
11/22/25 17:35 == 46.7	11/22/25 22:05 == 46.9	11/23/25 2:35 == 47.1	11/23/25 7:05 == 46.8
11/22/25 17:40 == 47	11/22/25 22:10 == 46.9	11/23/25 2:40 == 47.1	11/23/25 7:10 == 47
11/22/25 17:45 == 47	11/22/25 22:15 == 46.9	11/23/25 2:45 == 47.1	11/23/25 7:15 == 46.9
11/22/25 17:50 == 46.9	11/22/25 22:20 == 46.9	11/23/25 2:50 == 47	11/23/25 7:20 == 46.9
11/22/25 17:55 == 46.8	11/22/25 22:25 == 47	11/23/25 2:55 == 47	11/23/25 7:25 == 47
11/22/25 18:00 == 46.8	11/22/25 22:30 == 46.9	11/23/25 3:00 == 47	11/23/25 7:30 == 47
11/22/25 18:05 == 46.7	11/22/25 22:35 == 46.8	11/23/25 3:05 == 47	11/23/25 7:35 == 47
11/22/25 18:10 == 46.7	11/22/25 22:40 == 46.9	11/23/25 3:10 == 46.9	11/23/25 7:40 == 47
11/22/25 18:15 == 46.8	11/22/25 22:45 == 47	11/23/25 3:15 == 46.9	11/23/25 7:45 == 46.8
11/22/25 18:20 == 46.9	11/22/25 22:50 == 47	11/23/25 3:20 == 47	11/23/25 7:50 == 46.8
11/22/25 18:25 == 47.1	11/22/25 22:55 == 46.9	11/23/25 3:25 == 47.1	11/23/25 7:55 == 47
11/22/25 18:30 == 47	11/22/25 23:00 == 46.8	11/23/25 3:30 == 47.1	11/23/25 8:00 == 47.1
11/22/25 18:35 == 46.9	11/22/25 23:05 == 46.8	11/23/25 3:35 == 47.1	11/23/25 8:05 == 46.9
11/22/25 18:40 == 47	11/22/25 23:10 == 46.9	11/23/25 3:40 == 47.1	11/23/25 8:10 == 46.9
11/22/25 18:45 == 46.9	11/22/25 23:15 == 46.9	11/23/25 3:45 == 46.9	11/23/25 8:15 == 46.8
11/22/25 18:50 == 46.9	11/22/25 23:20 == 47	11/23/25 3:50 == 46.8	11/23/25 8:20 == 46.8
11/22/25 18:55 == 46.8	11/22/25 23:25 == 47	11/23/25 3:55 == 47	11/23/25 8:25 == 46.9
11/22/25 19:00 == 47.1	11/22/25 23:30 == 47	11/23/25 4:00 == 46.9	11/23/25 8:30 == 47
11/22/25 19:05 == 46.9	11/22/25 23:35 == 46.9	11/23/25 4:05 == 46.9	11/23/25 8:35 == 47
11/22/25 19:10 == 46.7	11/22/25 23:40 == 46.7	11/23/25 4:10 == 47.1	11/23/25 8:40 == 47
11/22/25 19:15 == 47	11/22/25 23:45 == 47.1	11/23/25 4:15 == 47	11/23/25 8:45 == 47
11/22/25 19:20 == 47.1	11/22/25 23:50 == 46.9	11/23/25 4:20 == 47	11/23/25 8:50 == 46.9
11/22/25 19:25 == 46.8	11/22/25 23:55 == 47	11/23/25 4:25 == 47.1	11/23/25 8:55 == 46.8
11/22/25 19:30 == 46.8	11/23/25 0:00 == 46.9	11/23/25 4:30 == 47	11/23/25 9:00 == 46.8
11/22/25 19:35 == 46.8	11/23/25 0:05 == 47	11/23/25 4:35 == 46.8	11/23/25 9:05 == 46.9
11/22/25 19:40 == 46.9	11/23/25 0:10 == 47	11/23/25 4:40 == 47	11/23/25 9:10 == 47
11/22/25 19:45 == 47	11/23/25 0:15 == 46.9	11/23/25 4:45 == 46.9	11/23/25 9:15 == 46.9
11/22/25 19:50 == 47	11/23/25 0:20 == 46.9	11/23/25 4:50 == 47	11/23/25 9:20 == 47
11/22/25 19:55 == 46.9	11/23/25 0:25 == 47	11/23/25 4:55 == 47.1	11/23/25 9:25 == 46.9
11/22/25 20:00 == 46.8	11/23/25 0:30 == 47	11/23/25 5:00 == 46.9	11/23/25 9:30 == 46.9
11/22/25 20:05 == 46.9	11/23/25 0:35 == 47	11/23/25 5:05 == 46.8	11/23/25 9:35 == 46.8
11/22/25 20:10 == 46.9	11/23/25 0:40 == 47	11/23/25 5:10 == 46.8	11/23/25 9:40 == 46.9
11/22/25 20:15 == 46.9	11/23/25 0:45 == 47	11/23/25 5:15 == 46.9	11/23/25 9:45 == 47
11/22/25 20:20 == 46.9	11/23/25 0:50 == 46.9	11/23/25 5:20 == 47	11/23/25 9:50 == 46.9
11/22/25 20:25 == 46.8	11/23/25 0:55 == 47	11/23/25 5:25 == 46.9	11/23/25 9:55 == 46.8
11/22/25 20:30 == 46.8	11/23/25 1:00 == 47	11/23/25 5:30 == 46.9	11/23/25 10:00 == 47
11/22/25 20:35 == 47	11/23/25 1:05 == 46.9	11/23/25 5:35 == 47.1	11/23/25 10:05 == 46.9
11/22/25 20:40 == 46.9	11/23/25 1:10 == 47	11/23/25 5:40 == 47	11/23/25 10:10 == 46.8
11/22/25 20:45 == 47	11/23/25 1:15 == 47	11/23/25 5:45 == 46.8	11/23/25 10:15 == 46.9
11/22/25 20:50 == 46.9	11/23/25 1:20 == 46.8	11/23/25 5:50 == 47	11/23/25 10:20 == 46.9
11/22/25 20:55 == 46.8	11/23/25 1:25 == 46.9	11/23/25 5:55 == 47	11/23/25 10:25 == 46.9
11/22/25 21:00 == 47	11/23/25 1:30 == 47	11/23/25 6:00 == 47	11/23/25 10:30 == 46.9
11/22/25 21:05 == 46.8	11/23/25 1:35 == 46.7	11/23/25 6:05 == 47	11/23/25 10:35 == 46.9
11/22/25 21:10 == 46.9	11/23/25 1:40 == 46.8	11/23/25 6:10 == 46.7	11/23/25 10:40 == 47
11/22/25 21:15 == 47.1	11/23/25 1:45 == 46.9	11/23/25 6:15 == 46.8	11/23/25 10:45 == 46.9
11/22/25 21:20 == 46.7	11/23/25 1:50 == 47	11/23/25 6:20 == 47	11/23/25 10:50 == 46.8
11/22/25 21:25 == 47	11/23/25 1:55 == 47	11/23/25 6:25 == 47	11/23/25 10:55 == 46.9

Pumpback Station Discharge (0364)

11/23/25 11:00 == 46.9	11/23/25 15:30 == 47	11/23/25 20:00 == 47	11/24/25 0:30 == 47
11/23/25 11:05 == 46.9	11/23/25 15:35 == 46.9	11/23/25 20:05 == 46.9	11/24/25 0:35 == 46.8
11/23/25 11:10 == 46.9	11/23/25 15:40 == 46.9	11/23/25 20:10 == 46.9	11/24/25 0:40 == 47.1
11/23/25 11:15 == 46.9	11/23/25 15:45 == 46.9	11/23/25 20:15 == 47.1	11/24/25 0:45 == 46.9
11/23/25 11:20 == 46.8	11/23/25 15:50 == 46.8	11/23/25 20:20 == 46.9	11/24/25 0:50 == 47.2
11/23/25 11:25 == 46.9	11/23/25 15:55 == 46.7	11/23/25 20:25 == 46.9	11/24/25 0:55 == 47
11/23/25 11:30 == 46.9	11/23/25 16:00 == 46.7	11/23/25 20:30 == 47.1	11/24/25 1:00 == 46.9
11/23/25 11:35 == 47.1	11/23/25 16:05 == 46.9	11/23/25 20:35 == 47	11/24/25 1:05 == 46.8
11/23/25 11:40 == 46.8	11/23/25 16:10 == 47	11/23/25 20:40 == 47	11/24/25 1:10 == 47
11/23/25 11:45 == 46.9	11/23/25 16:15 == 46.9	11/23/25 20:45 == 46.9	11/24/25 1:15 == 46.9
11/23/25 11:50 == 47	11/23/25 16:20 == 46.8	11/23/25 20:50 == 46.9	11/24/25 1:20 == 47
11/23/25 11:55 == 47	11/23/25 16:25 == 46.8	11/23/25 20:55 == 46.9	11/24/25 1:25 == 46.9
11/23/25 12:00 == 46.9	11/23/25 16:30 == 46.9	11/23/25 21:00 == 46.8	11/24/25 1:30 == 46.9
11/23/25 12:05 == 46.9	11/23/25 16:35 == 47.1	11/23/25 21:05 == 47	11/24/25 1:35 == 46.9
11/23/25 12:10 == 46.9	11/23/25 16:40 == 47.1	11/23/25 21:10 == 47	11/24/25 1:40 == 46.9
11/23/25 12:15 == 46.8	11/23/25 16:45 == 47	11/23/25 21:15 == 46.9	11/24/25 1:45 == 46.8
11/23/25 12:20 == 46.8	11/23/25 16:50 == 46.9	11/23/25 21:20 == 46.9	11/24/25 1:50 == 46.8
11/23/25 12:25 == 46.9	11/23/25 16:55 == 46.9	11/23/25 21:25 == 47.1	11/24/25 1:55 == 47
11/23/25 12:30 == 46.9	11/23/25 17:00 == 46.9	11/23/25 21:30 == 47.1	11/24/25 2:00 == 47
11/23/25 12:35 == 46.9	11/23/25 17:05 == 46.9	11/23/25 21:35 == 47	11/24/25 2:05 == 46.9
11/23/25 12:40 == 47	11/23/25 17:10 == 47	11/23/25 21:40 == 47	11/24/25 2:10 == 47
11/23/25 12:45 == 47.1	11/23/25 17:15 == 47	11/23/25 21:45 == 47.1	11/24/25 2:15 == 47
11/23/25 12:50 == 47	11/23/25 17:20 == 47	11/23/25 21:50 == 46.9	11/24/25 2:20 == 47
11/23/25 12:55 == 47.1	11/23/25 17:25 == 46.9	11/23/25 21:55 == 46.9	11/24/25 2:25 == 46.9
11/23/25 13:00 == 47.1	11/23/25 17:30 == 46.7	11/23/25 22:00 == 46.9	11/24/25 2:30 == 46.8
11/23/25 13:05 == 46.9	11/23/25 17:35 == 46.8	11/23/25 22:05 == 46.9	11/24/25 2:35 == 46.8
11/23/25 13:10 == 46.9	11/23/25 17:40 == 46.9	11/23/25 22:10 == 46.8	11/24/25 2:40 == 46.9
11/23/25 13:15 == 46.7	11/23/25 17:45 == 46.8	11/23/25 22:15 == 47	11/24/25 2:45 == 46.9
11/23/25 13:20 == 46.7	11/23/25 17:50 == 46.8	11/23/25 22:20 == 46.8	11/24/25 2:50 == 46.9
11/23/25 13:25 == 47	11/23/25 17:55 == 47	11/23/25 22:25 == 47	11/24/25 2:55 == 46.8
11/23/25 13:30 == 46.9	11/23/25 18:00 == 46.9	11/23/25 22:30 == 47	11/24/25 3:00 == 46.9
11/23/25 13:35 == 47	11/23/25 18:05 == 47	11/23/25 22:35 == 46.9	11/24/25 3:05 == 47
11/23/25 13:40 == 47	11/23/25 18:10 == 46.9	11/23/25 22:40 == 47	11/24/25 3:10 == 47
11/23/25 13:45 == 47	11/23/25 18:15 == 46.8	11/23/25 22:45 == 46.7	11/24/25 3:15 == 46.9
11/23/25 13:50 == 46.9	11/23/25 18:20 == 46.9	11/23/25 22:50 == 46.7	11/24/25 3:20 == 47.1
11/23/25 13:55 == 46.9	11/23/25 18:25 == 47	11/23/25 22:55 == 46.8	11/24/25 3:25 == 47
11/23/25 14:00 == 46.8	11/23/25 18:30 == 47	11/23/25 23:00 == 46.9	11/24/25 3:30 == 47
11/23/25 14:05 == 46.9	11/23/25 18:35 == 46.9	11/23/25 23:05 == 46.8	11/24/25 3:35 == 46.9
11/23/25 14:10 == 46.9	11/23/25 18:40 == 46.8	11/23/25 23:10 == 47.1	11/24/25 3:40 == 46.9
11/23/25 14:15 == 46.9	11/23/25 18:45 == 46.9	11/23/25 23:15 == 46.9	11/24/25 3:45 == 46.7
11/23/25 14:20 == 47	11/23/25 18:50 == 46.9	11/23/25 23:20 == 46.8	11/24/25 3:50 == 46.8
11/23/25 14:25 == 46.9	11/23/25 18:55 == 46.9	11/23/25 23:25 == 46.8	11/24/25 3:55 == 47
11/23/25 14:30 == 46.8	11/23/25 19:00 == 47.1	11/23/25 23:30 == 46.9	11/24/25 4:00 == 46.9
11/23/25 14:35 == 46.9	11/23/25 19:05 == 46.9	11/23/25 23:35 == 47	11/24/25 4:05 == 46.9
11/23/25 14:40 == 47	11/23/25 19:10 == 46.9	11/23/25 23:40 == 46.9	11/24/25 4:10 == 47
11/23/25 14:45 == 47	11/23/25 19:15 == 47	11/23/25 23:45 == 46.9	11/24/25 4:15 == 47
11/23/25 14:50 == 47	11/23/25 19:20 == 46.9	11/23/25 23:50 == 46.9	11/24/25 4:20 == 46.9
11/23/25 14:55 == 46.9	11/23/25 19:25 == 46.9	11/23/25 23:55 == 47	11/24/25 4:25 == 47
11/23/25 15:00 == 46.9	11/23/25 19:30 == 46.9	11/24/25 0:00 == 47.1	11/24/25 4:30 == 46.8
11/23/25 15:05 == 46.9	11/23/25 19:35 == 46.9	11/24/25 0:05 == 47	11/24/25 4:35 == 46.8
11/23/25 15:10 == 46.8	11/23/25 19:40 == 47	11/24/25 0:10 == 46.8	11/24/25 4:40 == 47
11/23/25 15:15 == 46.9	11/23/25 19:45 == 46.8	11/24/25 0:15 == 47	11/24/25 4:45 == 47.1
11/23/25 15:20 == 46.8	11/23/25 19:50 == 46.9	11/24/25 0:20 == 47.2	11/24/25 4:50 == 47
11/23/25 15:25 == 46.9	11/23/25 19:55 == 47	11/24/25 0:25 == 47	11/24/25 4:55 == 47

Pumpback Station Discharge (0364)

11/24/25 5:00 == 47	11/24/25 9:30 == 47.1	11/24/25 14:00 == 47	11/24/25 18:30 == 47
11/24/25 5:05 == 47	11/24/25 9:35 == 46.9	11/24/25 14:05 == 46.9	11/24/25 18:35 == 46.9
11/24/25 5:10 == 46.9	11/24/25 9:40 == 46.9	11/24/25 14:10 == 46.9	11/24/25 18:40 == 46.9
11/24/25 5:15 == 47	11/24/25 9:45 == 47.1	11/24/25 14:15 == 47	11/24/25 18:45 == 46.9
11/24/25 5:20 == 47	11/24/25 9:50 == 47	11/24/25 14:20 == 46.9	11/24/25 18:50 == 46.9
11/24/25 5:25 == 47	11/24/25 9:55 == 47.1	11/24/25 14:25 == 46.8	11/24/25 18:55 == 46.9
11/24/25 5:30 == 47	11/24/25 10:00 == 47	11/24/25 14:30 == 46.8	11/24/25 19:00 == 46.9
11/24/25 5:35 == 47	11/24/25 10:05 == 46.9	11/24/25 14:35 == 46.9	11/24/25 19:05 == 47
11/24/25 5:40 == 46.9	11/24/25 10:10 == 47	11/24/25 14:40 == 47.1	11/24/25 19:10 == 46.9
11/24/25 5:45 == 47	11/24/25 10:15 == 46.9	11/24/25 14:45 == 47	11/24/25 19:15 == 47
11/24/25 5:50 == 47	11/24/25 10:20 == 47	11/24/25 14:50 == 47	11/24/25 19:20 == 46.9
11/24/25 5:55 == 46.8	11/24/25 10:25 == 46.9	11/24/25 14:55 == 47	11/24/25 19:25 == 46.9
11/24/25 6:00 == 47	11/24/25 10:30 == 47	11/24/25 15:00 == 46.9	11/24/25 19:30 == 46.7
11/24/25 6:05 == 46.9	11/24/25 10:35 == 46.9	11/24/25 15:05 == 46.8	11/24/25 19:35 == 46.9
11/24/25 6:10 == 47	11/24/25 10:40 == 47.1	11/24/25 15:10 == 46.9	11/24/25 19:40 == 46.9
11/24/25 6:15 == 47.1	11/24/25 10:45 == 47	11/24/25 15:15 == 46.9	11/24/25 19:45 == 46.8
11/24/25 6:20 == 46.9	11/24/25 10:50 == 47	11/24/25 15:20 == 46.9	11/24/25 19:50 == 46.9
11/24/25 6:25 == 47	11/24/25 10:55 == 47	11/24/25 15:25 == 46.8	11/24/25 19:55 == 46.8
11/24/25 6:30 == 47	11/24/25 11:00 == 47	11/24/25 15:30 == 46.8	11/24/25 20:00 == 46.8
11/24/25 6:35 == 47	11/24/25 11:05 == 47.1	11/24/25 15:35 == 46.7	11/24/25 20:05 == 47.1
11/24/25 6:40 == 47	11/24/25 11:10 == 47	11/24/25 15:40 == 46.8	11/24/25 20:10 == 47
11/24/25 6:45 == 47.1	11/24/25 11:15 == 47	11/24/25 15:45 == 46.9	11/24/25 20:15 == 46.9
11/24/25 6:50 == 46.9	11/24/25 11:20 == 47.1	11/24/25 15:50 == 47	11/24/25 20:20 == 47
11/24/25 6:55 == 46.9	11/24/25 11:25 == 47.1	11/24/25 15:55 == 46.9	11/24/25 20:25 == 47
11/24/25 7:00 == 47.1	11/24/25 11:30 == 47.1	11/24/25 16:00 == 46.9	11/24/25 20:30 == 47
11/24/25 7:05 == 46.9	11/24/25 11:35 == 47.2	11/24/25 16:05 == 46.9	11/24/25 20:35 == 47
11/24/25 7:10 == 46.9	11/24/25 11:40 == 47.3	11/24/25 16:10 == 47	11/24/25 20:40 == 47
11/24/25 7:15 == 47	11/24/25 11:45 == 47.1	11/24/25 16:15 == 47.1	11/24/25 20:45 == 47
11/24/25 7:20 == 47.1	11/24/25 11:50 == 46.9	11/24/25 16:20 == 47	11/24/25 20:50 == 46.9
11/24/25 7:25 == 46.9	11/24/25 11:55 == 47.1	11/24/25 16:25 == 46.8	11/24/25 20:55 == 46.9
11/24/25 7:30 == 47	11/24/25 12:00 == 47	11/24/25 16:30 == 46.8	11/24/25 21:00 == 47
11/24/25 7:35 == 46.9	11/24/25 12:05 == 47.1	11/24/25 16:35 == 46.9	11/24/25 21:05 == 46.9
11/24/25 7:40 == 47	11/24/25 12:10 == 47.1	11/24/25 16:40 == 47	11/24/25 21:10 == 46.9
11/24/25 7:45 == 47	11/24/25 12:15 == 47	11/24/25 16:45 == 46.8	11/24/25 21:15 == 46.9
11/24/25 7:50 == 46.9	11/24/25 12:20 == 47.1	11/24/25 16:50 == 46.9	11/24/25 21:20 == 46.9
11/24/25 7:55 == 46.9	11/24/25 12:25 == 46.9	11/24/25 16:55 == 46.8	11/24/25 21:25 == 46.8
11/24/25 8:00 == 46.9	11/24/25 12:30 == 47.2	11/24/25 17:00 == 46.9	11/24/25 21:30 == 46.9
11/24/25 8:05 == 47	11/24/25 12:35 == 47	11/24/25 17:05 == 46.8	11/24/25 21:35 == 46.9
11/24/25 8:10 == 46.9	11/24/25 12:40 == 46.9	11/24/25 17:10 == 46.8	11/24/25 21:40 == 46.9
11/24/25 8:15 == 47	11/24/25 12:45 == 46.9	11/24/25 17:15 == 46.6	11/24/25 21:45 == 46.8
11/24/25 8:20 == 47	11/24/25 12:50 == 46.9	11/24/25 17:20 == 47	11/24/25 21:50 == 46.8
11/24/25 8:25 == 46.9	11/24/25 12:55 == 47	11/24/25 17:25 == 47	11/24/25 21:55 == 46.8
11/24/25 8:30 == 46.9	11/24/25 13:00 == 47	11/24/25 17:30 == 46.9	11/24/25 22:00 == 46.8
11/24/25 8:35 == 47	11/24/25 13:05 == 47	11/24/25 17:35 == 46.8	11/24/25 22:05 == 46.9
11/24/25 8:40 == 47	11/24/25 13:10 == 47.1	11/24/25 17:40 == 46.9	11/24/25 22:10 == 47
11/24/25 8:45 == 47	11/24/25 13:15 == 47	11/24/25 17:45 == 46.9	11/24/25 22:15 == 47
11/24/25 8:50 == 46.8	11/24/25 13:20 == 46.9	11/24/25 17:50 == 46.8	11/24/25 22:20 == 46.9
11/24/25 8:55 == 46.7	11/24/25 13:25 == 47	11/24/25 17:55 == 46.8	11/24/25 22:25 == 47
11/24/25 9:00 == 46.8	11/24/25 13:30 == 47	11/24/25 18:00 == 46.8	11/24/25 22:30 == 46.9
11/24/25 9:05 == 46.8	11/24/25 13:35 == 46.9	11/24/25 18:05 == 46.9	11/24/25 22:35 == 46.8
11/24/25 9:10 == 46.9	11/24/25 13:40 == 47	11/24/25 18:10 == 47	11/24/25 22:40 == 46.9
11/24/25 9:15 == 47	11/24/25 13:45 == 47	11/24/25 18:15 == 46.9	11/24/25 22:45 == 46.9
11/24/25 9:20 == 46.9	11/24/25 13:50 == 46.9	11/24/25 18:20 == 47	11/24/25 22:50 == 46.9
11/24/25 9:25 == 47	11/24/25 13:55 == 47	11/24/25 18:25 == 47	11/24/25 22:55 == 46.9

Pumpback Station Discharge (0364)

11/24/25 23:00 == 47	11/25/25 3:30 == 46.9	11/25/25 8:00 == 46.9	11/25/25 12:30 == 47
11/24/25 23:05 == 46.9	11/25/25 3:35 == 46.9	11/25/25 8:05 == 47	11/25/25 12:35 == 47
11/24/25 23:10 == 46.8	11/25/25 3:40 == 47	11/25/25 8:10 == 46.9	11/25/25 12:40 == 47
11/24/25 23:15 == 46.9	11/25/25 3:45 == 47.1	11/25/25 8:15 == 46.9	11/25/25 12:45 == 46.8
11/24/25 23:20 == 46.9	11/25/25 3:50 == 47	11/25/25 8:20 == 46.9	11/25/25 12:50 == 46.9
11/24/25 23:25 == 46.9	11/25/25 3:55 == 46.9	11/25/25 8:25 == 46.9	11/25/25 12:55 == 47
11/24/25 23:30 == 46.9	11/25/25 4:00 == 47	11/25/25 8:30 == 47	11/25/25 13:00 == 46.9
11/24/25 23:35 == 47	11/25/25 4:05 == 47.1	11/25/25 8:35 == 47	11/25/25 13:05 == 46.9
11/24/25 23:40 == 47	11/25/25 4:10 == 46.9	11/25/25 8:40 == 47	11/25/25 13:10 == 47
11/24/25 23:45 == 46.9	11/25/25 4:15 == 47	11/25/25 8:45 == 47	11/25/25 13:15 == 47
11/24/25 23:50 == 46.8	11/25/25 4:20 == 46.9	11/25/25 8:50 == 47	11/25/25 13:20 == 46.9
11/24/25 23:55 == 46.9	11/25/25 4:25 == 46.8	11/25/25 8:55 == 46.9	11/25/25 13:25 == 47.1
11/25/25 0:00 == 46.9	11/25/25 4:30 == 46.9	11/25/25 9:00 == 46.9	11/25/25 13:30 == 47.1
11/25/25 0:05 == 46.8	11/25/25 4:35 == 46.9	11/25/25 9:05 == 46.9	11/25/25 13:35 == 46.9
11/25/25 0:10 == 46.9	11/25/25 4:40 == 47	11/25/25 9:10 == 46.9	11/25/25 13:40 == 46.9
11/25/25 0:15 == 46.8	11/25/25 4:45 == 47	11/25/25 9:15 == 46.8	11/25/25 13:45 == 46.9
11/25/25 0:20 == 46.9	11/25/25 4:50 == 47.3	11/25/25 9:20 == 46.8	11/25/25 13:50 == 47
11/25/25 0:25 == 46.9	11/25/25 4:55 == 47.1	11/25/25 9:25 == 46.8	11/25/25 13:55 == 46.8
11/25/25 0:30 == 47	11/25/25 5:00 == 46.9	11/25/25 9:30 == 47.1	11/25/25 14:00 == 46.8
11/25/25 0:35 == 47	11/25/25 5:05 == 46.9	11/25/25 9:35 == 46.7	11/25/25 14:05 == 46.9
11/25/25 0:40 == 46.8	11/25/25 5:10 == 46.9	11/25/25 9:40 == 46.8	11/25/25 14:10 == 47
11/25/25 0:45 == 46.9	11/25/25 5:15 == 47	11/25/25 9:45 == 47	11/25/25 14:15 == 46.9
11/25/25 0:50 == 46.8	11/25/25 5:20 == 47	11/25/25 9:50 == 46.8	11/25/25 14:20 == 47.1
11/25/25 0:55 == 46.8	11/25/25 5:25 == 47	11/25/25 9:55 == 46.9	11/25/25 14:25 == 46.7
11/25/25 1:00 == 47	11/25/25 5:30 == 47	11/25/25 10:00 == 47	11/25/25 14:30 == 46.8
11/25/25 1:05 == 47	11/25/25 5:35 == 47	11/25/25 10:05 == 47	11/25/25 14:35 == 46.8
11/25/25 1:10 == 46.8	11/25/25 5:40 == 47	11/25/25 10:10 == 46.8	11/25/25 14:40 == 47
11/25/25 1:15 == 46.9	11/25/25 5:45 == 47	11/25/25 10:15 == 46.8	11/25/25 14:45 == 47
11/25/25 1:20 == 47	11/25/25 5:50 == 47	11/25/25 10:20 == 46.9	11/25/25 14:50 == 46.8
11/25/25 1:25 == 46.9	11/25/25 5:55 == 47	11/25/25 10:25 == 46.9	11/25/25 14:55 == 46.9
11/25/25 1:30 == 46.8	11/25/25 6:00 == 47	11/25/25 10:30 == 46.9	11/25/25 15:00 == 46.9
11/25/25 1:35 == 46.9	11/25/25 6:05 == 47	11/25/25 10:35 == 47	11/25/25 15:05 == 46.9
11/25/25 1:40 == 46.9	11/25/25 6:10 == 46.9	11/25/25 10:40 == 47	11/25/25 15:10 == 46.9
11/25/25 1:45 == 46.9	11/25/25 6:15 == 46.9	11/25/25 10:45 == 46.9	11/25/25 15:15 == 47
11/25/25 1:50 == 47	11/25/25 6:20 == 47	11/25/25 10:50 == 46.8	11/25/25 15:20 == 47
11/25/25 1:55 == 47	11/25/25 6:25 == 47.1	11/25/25 10:55 == 46.8	11/25/25 15:25 == 46.8
11/25/25 2:00 == 47	11/25/25 6:30 == 47.1	11/25/25 11:00 == 46.9	11/25/25 15:30 == 46.8
11/25/25 2:05 == 46.8	11/25/25 6:35 == 47.1	11/25/25 11:05 == 46.9	11/25/25 15:35 == 46.9
11/25/25 2:10 == 46.8	11/25/25 6:40 == 47.1	11/25/25 11:10 == 46.9	11/25/25 15:40 == 46.9
11/25/25 2:15 == 46.8	11/25/25 6:45 == 46.9	11/25/25 11:15 == 46.9	11/25/25 15:45 == 46.8
11/25/25 2:20 == 47	11/25/25 6:50 == 46.9	11/25/25 11:20 == 47	11/25/25 15:50 == 46.9
11/25/25 2:25 == 47.1	11/25/25 6:55 == 47	11/25/25 11:25 == 46.9	11/25/25 15:55 == 46.8
11/25/25 2:30 == 47	11/25/25 7:00 == 47	11/25/25 11:30 == 47	11/25/25 16:00 == 46.8
11/25/25 2:35 == 46.9	11/25/25 7:05 == 47	11/25/25 11:35 == 47	11/25/25 16:05 == 46.9
11/25/25 2:40 == 46.9	11/25/25 7:10 == 47.1	11/25/25 11:40 == 46.9	11/25/25 16:10 == 46.9
11/25/25 2:45 == 47	11/25/25 7:15 == 47.1	11/25/25 11:45 == 46.8	11/25/25 16:15 == 46.9
11/25/25 2:50 == 46.9	11/25/25 7:20 == 47.1	11/25/25 11:50 == 46.9	11/25/25 16:20 == 47
11/25/25 2:55 == 46.9	11/25/25 7:25 == 46.9	11/25/25 11:55 == 46.8	11/25/25 16:25 == 47.1
11/25/25 3:00 == 46.9	11/25/25 7:30 == 47	11/25/25 12:00 == 46.9	11/25/25 16:30 == 47
11/25/25 3:05 == 47	11/25/25 7:35 == 46.9	11/25/25 12:05 == 47.1	11/25/25 16:35 == 47.1
11/25/25 3:10 == 46.9	11/25/25 7:40 == 47.1	11/25/25 12:10 == 46.9	11/25/25 16:40 == 47
11/25/25 3:15 == 47.1	11/25/25 7:45 == 46.9	11/25/25 12:15 == 46.9	11/25/25 16:45 == 47
11/25/25 3:20 == 47	11/25/25 7:50 == 47	11/25/25 12:20 == 47	11/25/25 16:50 == 46.8
11/25/25 3:25 == 46.9	11/25/25 7:55 == 46.8	11/25/25 12:25 == 47	11/25/25 16:55 == 46.8

Pumpback Station Discharge (0364)

11/25/25 17:00 == 46.9	11/25/25 21:30 == 47	11/26/25 2:00 == 47	11/26/25 6:30 == 47.1
11/25/25 17:05 == 46.9	11/25/25 21:35 == 47	11/26/25 2:05 == 47.1	11/26/25 6:35 == 46.9
11/25/25 17:10 == 46.9	11/25/25 21:40 == 47	11/26/25 2:10 == 46.9	11/26/25 6:40 == 47
11/25/25 17:15 == 46.9	11/25/25 21:45 == 47	11/26/25 2:15 == 46.9	11/26/25 6:45 == 47
11/25/25 17:20 == 46.9	11/25/25 21:50 == 47	11/26/25 2:20 == 46.9	11/26/25 6:50 == 46.9
11/25/25 17:25 == 46.9	11/25/25 21:55 == 46.9	11/26/25 2:25 == 46.9	11/26/25 6:55 == 47
11/25/25 17:30 == 46.9	11/25/25 22:00 == 47	11/26/25 2:30 == 47	11/26/25 7:00 == 46.9
11/25/25 17:35 == 46.9	11/25/25 22:05 == 46.9	11/26/25 2:35 == 47	11/26/25 7:05 == 46.9
11/25/25 17:40 == 46.9	11/25/25 22:10 == 46.9	11/26/25 2:40 == 46.9	11/26/25 7:10 == 46.9
11/25/25 17:45 == 46.9	11/25/25 22:15 == 47	11/26/25 2:45 == 46.9	11/26/25 7:15 == 47
11/25/25 17:50 == 46.8	11/25/25 22:20 == 47	11/26/25 2:50 == 46.8	11/26/25 7:20 == 47
11/25/25 17:55 == 46.9	11/25/25 22:25 == 46.9	11/26/25 2:55 == 46.9	11/26/25 7:25 == 46.9
11/25/25 18:00 == 46.9	11/25/25 22:30 == 47	11/26/25 3:00 == 46.9	11/26/25 7:30 == 46.9
11/25/25 18:05 == 46.9	11/25/25 22:35 == 47	11/26/25 3:05 == 46.9	11/26/25 7:35 == 46.9
11/25/25 18:10 == 46.8	11/25/25 22:40 == 47.1	11/26/25 3:10 == 47	11/26/25 7:40 == 46.9
11/25/25 18:15 == 46.9	11/25/25 22:45 == 47	11/26/25 3:15 == 46.9	11/26/25 7:45 == 46.9
11/25/25 18:20 == 46.9	11/25/25 22:50 == 47.1	11/26/25 3:20 == 46.9	11/26/25 7:50 == 46.9
11/25/25 18:25 == 46.8	11/25/25 22:55 == 47	11/26/25 3:25 == 46.9	11/26/25 7:55 == 46.9
11/25/25 18:30 == 46.8	11/25/25 23:00 == 46.8	11/26/25 3:30 == 46.8	11/26/25 8:00 == 46.8
11/25/25 18:35 == 47.1	11/25/25 23:05 == 47	11/26/25 3:35 == 46.8	11/26/25 8:05 == 46.8
11/25/25 18:40 == 47.1	11/25/25 23:10 == 46.9	11/26/25 3:40 == 47	11/26/25 8:10 == 46.9
11/25/25 18:45 == 46.9	11/25/25 23:15 == 46.8	11/26/25 3:45 == 47	11/26/25 8:15 == 46.9
11/25/25 18:50 == 47	11/25/25 23:20 == 47.1	11/26/25 3:50 == 47	11/26/25 8:20 == 46.9
11/25/25 18:55 == 47	11/25/25 23:25 == 47	11/26/25 3:55 == 46.9	11/26/25 8:25 == 46.8
11/25/25 19:00 == 47	11/25/25 23:30 == 47	11/26/25 4:00 == 46.9	11/26/25 8:30 == 47
11/25/25 19:05 == 47	11/25/25 23:35 == 47	11/26/25 4:05 == 47	11/26/25 8:35 == 46.9
11/25/25 19:10 == 46.9	11/25/25 23:40 == 47	11/26/25 4:10 == 46.9	11/26/25 8:40 == 46.9
11/25/25 19:15 == 47	11/25/25 23:45 == 47	11/26/25 4:15 == 47.1	11/26/25 8:45 == 46.9
11/25/25 19:20 == 47	11/25/25 23:50 == 46.9	11/26/25 4:20 == 46.9	11/26/25 8:50 == 47.1
11/25/25 19:25 == 46.9	11/25/25 23:55 == 46.8	11/26/25 4:25 == 46.8	11/26/25 8:55 == 47
11/25/25 19:30 == 46.9	11/26/25 0:00 == 47	11/26/25 4:30 == 46.9	11/26/25 9:00 == 46.9
11/25/25 19:35 == 46.8	11/26/25 0:05 == 47.1	11/26/25 4:35 == 47	11/26/25 9:05 == 46.7
11/25/25 19:40 == 47	11/26/25 0:10 == 46.9	11/26/25 4:40 == 46.9	11/26/25 9:10 == 46.9
11/25/25 19:45 == 47.1	11/26/25 0:15 == 47	11/26/25 4:45 == 46.8	11/26/25 9:15 == 46.9
11/25/25 19:50 == 47	11/26/25 0:20 == 47	11/26/25 4:50 == 47	11/26/25 9:20 == 46.8
11/25/25 19:55 == 47	11/26/25 0:25 == 46.9	11/26/25 4:55 == 47	11/26/25 9:25 == 47
11/25/25 20:00 == 47.1	11/26/25 0:30 == 46.9	11/26/25 5:00 == 47	11/26/25 9:30 == 46.8
11/25/25 20:05 == 47	11/26/25 0:35 == 46.9	11/26/25 5:05 == 46.9	11/26/25 9:35 == 46.9
11/25/25 20:10 == 47	11/26/25 0:40 == 46.9	11/26/25 5:10 == 46.8	11/26/25 9:40 == 46.9
11/25/25 20:15 == 47	11/26/25 0:45 == 46.8	11/26/25 5:15 == 46.9	11/26/25 9:45 == 47
11/25/25 20:20 == 47	11/26/25 0:50 == 46.9	11/26/25 5:20 == 47	11/26/25 9:50 == 46.9
11/25/25 20:25 == 46.9	11/26/25 0:55 == 47	11/26/25 5:25 == 47.1	11/26/25 9:55 == 46.8
11/25/25 20:30 == 47	11/26/25 1:00 == 46.9	11/26/25 5:30 == 46.9	11/26/25 10:00 == 46.9
11/25/25 20:35 == 46.9	11/26/25 1:05 == 46.9	11/26/25 5:35 == 46.9	11/26/25 10:05 == 46.9
11/25/25 20:40 == 46.9	11/26/25 1:10 == 46.8	11/26/25 5:40 == 46.9	11/26/25 10:10 == 47
11/25/25 20:45 == 47	11/26/25 1:15 == 46.9	11/26/25 5:45 == 46.8	11/26/25 10:15 == 46.9
11/25/25 20:50 == 46.9	11/26/25 1:20 == 47.1	11/26/25 5:50 == 46.9	11/26/25 10:20 == 46.9
11/25/25 20:55 == 46.9	11/26/25 1:25 == 46.9	11/26/25 5:55 == 47	11/26/25 10:25 == 46.9
11/25/25 21:00 == 46.8	11/26/25 1:30 == 47.2	11/26/25 6:00 == 47	11/26/25 10:30 == 46.9
11/25/25 21:05 == 47	11/26/25 1:35 == 47	11/26/25 6:05 == 47	11/26/25 10:35 == 46.6
11/25/25 21:10 == 47	11/26/25 1:40 == 46.9	11/26/25 6:10 == 46.8	11/26/25 10:40 == 46.8
11/25/25 21:15 == 47.1	11/26/25 1:45 == 46.7	11/26/25 6:15 == 46.9	11/26/25 10:45 == 46.9
11/25/25 21:20 == 46.9	11/26/25 1:50 == 46.8	11/26/25 6:20 == 47	11/26/25 10:50 == 47.1
11/25/25 21:25 == 46.8	11/26/25 1:55 == 46.9	11/26/25 6:25 == 47.1	11/26/25 10:55 == 46.9

Pumpback Station Discharge (0364)

11/26/25 11:00 == 46.9	11/26/25 15:30 == 46.8	11/26/25 20:00 == 46.9	11/27/25 0:30 == 46.9
11/26/25 11:05 == 47.1	11/26/25 15:35 == 46.8	11/26/25 20:05 == 47	11/27/25 0:35 == 46.9
11/26/25 11:10 == 46.9	11/26/25 15:40 == 47	11/26/25 20:10 == 47	11/27/25 0:40 == 47
11/26/25 11:15 == 46.8	11/26/25 15:45 == 46.7	11/26/25 20:15 == 46.8	11/27/25 0:45 == 46.9
11/26/25 11:20 == 46.9	11/26/25 15:50 == 46.9	11/26/25 20:20 == 47	11/27/25 0:50 == 46.9
11/26/25 11:25 == 47	11/26/25 15:55 == 46.9	11/26/25 20:25 == 46.9	11/27/25 0:55 == 46.9
11/26/25 11:30 == 46.8	11/26/25 16:00 == 46.8	11/26/25 20:30 == 46.9	11/27/25 1:00 == 46.8
11/26/25 11:35 == 47.1	11/26/25 16:05 == 46.8	11/26/25 20:35 == 47	11/27/25 1:05 == 46.9
11/26/25 11:40 == 47	11/26/25 16:10 == 46.8	11/26/25 20:40 == 47	11/27/25 1:10 == 46.8
11/26/25 11:45 == 46.9	11/26/25 16:15 == 46.9	11/26/25 20:45 == 46.9	11/27/25 1:15 == 46.9
11/26/25 11:50 == 47	11/26/25 16:20 == 46.8	11/26/25 20:50 == 46.8	11/27/25 1:20 == 46.8
11/26/25 11:55 == 46.9	11/26/25 16:25 == 46.8	11/26/25 20:55 == 46.8	11/27/25 1:25 == 46.9
11/26/25 12:00 == 46.9	11/26/25 16:30 == 46.8	11/26/25 21:00 == 46.8	11/27/25 1:30 == 46.9
11/26/25 12:05 == 46.9	11/26/25 16:35 == 46.8	11/26/25 21:05 == 46.7	11/27/25 1:35 == 46.8
11/26/25 12:10 == 46.9	11/26/25 16:40 == 46.9	11/26/25 21:10 == 46.7	11/27/25 1:40 == 46.8
11/26/25 12:15 == 46.9	11/26/25 16:45 == 46.9	11/26/25 21:15 == 46.8	11/27/25 1:45 == 46.9
11/26/25 12:20 == 47	11/26/25 16:50 == 46.9	11/26/25 21:20 == 46.9	11/27/25 1:50 == 46.9
11/26/25 12:25 == 47	11/26/25 16:55 == 46.8	11/26/25 21:25 == 47	11/27/25 1:55 == 46.9
11/26/25 12:30 == 47	11/26/25 17:00 == 46.8	11/26/25 21:30 == 47	11/27/25 2:00 == 47
11/26/25 12:35 == 46.9	11/26/25 17:05 == 46.9	11/26/25 21:35 == 46.8	11/27/25 2:05 == 46.9
11/26/25 12:40 == 46.9	11/26/25 17:10 == 46.8	11/26/25 21:40 == 46.8	11/27/25 2:10 == 46.9
11/26/25 12:45 == 46.8	11/26/25 17:15 == 46.9	11/26/25 21:45 == 46.8	11/27/25 2:15 == 46.9
11/26/25 12:50 == 46.6	11/26/25 17:20 == 46.9	11/26/25 21:50 == 46.8	11/27/25 2:20 == 46.8
11/26/25 12:55 == 46.9	11/26/25 17:25 == 46.9	11/26/25 21:55 == 46.8	11/27/25 2:25 == 46.8
11/26/25 13:00 == 47	11/26/25 17:30 == 46.9	11/26/25 22:00 == 46.8	11/27/25 2:30 == 46.8
11/26/25 13:05 == 46.9	11/26/25 17:35 == 46.9	11/26/25 22:05 == 46.8	11/27/25 2:35 == 46.8
11/26/25 13:10 == 46.8	11/26/25 17:40 == 46.8	11/26/25 22:10 == 46.9	11/27/25 2:40 == 46.8
11/26/25 13:15 == 46.9	11/26/25 17:45 == 46.8	11/26/25 22:15 == 47	11/27/25 2:45 == 46.9
11/26/25 13:20 == 47	11/26/25 17:50 == 46.9	11/26/25 22:20 == 47.1	11/27/25 2:50 == 47
11/26/25 13:25 == 47.1	11/26/25 17:55 == 46.8	11/26/25 22:25 == 47	11/27/25 2:55 == 47
11/26/25 13:30 == 46.9	11/26/25 18:00 == 46.8	11/26/25 22:30 == 46.8	11/27/25 3:00 == 47
11/26/25 13:35 == 46.8	11/26/25 18:05 == 46.8	11/26/25 22:35 == 46.9	11/27/25 3:05 == 47.1
11/26/25 13:40 == 46.8	11/26/25 18:10 == 47	11/26/25 22:40 == 47	11/27/25 3:10 == 46.9
11/26/25 13:45 == 46.8	11/26/25 18:15 == 46.9	11/26/25 22:45 == 47.1	11/27/25 3:15 == 47.1
11/26/25 13:50 == 46.7	11/26/25 18:20 == 46.9	11/26/25 22:50 == 46.9	11/27/25 3:20 == 47.1
11/26/25 13:55 == 46.7	11/26/25 18:25 == 46.9	11/26/25 22:55 == 46.9	11/27/25 3:25 == 46.9
11/26/25 14:00 == 46.8	11/26/25 18:30 == 46.8	11/26/25 23:00 == 46.8	11/27/25 3:30 == 46.8
11/26/25 14:05 == 46.9	11/26/25 18:35 == 47	11/26/25 23:05 == 46.7	11/27/25 3:35 == 46.8
11/26/25 14:10 == 46.9	11/26/25 18:40 == 46.9	11/26/25 23:10 == 46.9	11/27/25 3:40 == 46.8
11/26/25 14:15 == 46.9	11/26/25 18:45 == 46.7	11/26/25 23:15 == 46.8	11/27/25 3:45 == 47
11/26/25 14:20 == 46.9	11/26/25 18:50 == 46.8	11/26/25 23:20 == 46.8	11/27/25 3:50 == 47
11/26/25 14:25 == 46.9	11/26/25 18:55 == 46.9	11/26/25 23:25 == 46.9	11/27/25 3:55 == 47
11/26/25 14:30 == 46.9	11/26/25 19:00 == 47	11/26/25 23:30 == 46.9	11/27/25 4:00 == 47
11/26/25 14:35 == 47	11/26/25 19:05 == 47	11/26/25 23:35 == 47	11/27/25 4:05 == 46.9
11/26/25 14:40 == 47	11/26/25 19:10 == 46.9	11/26/25 23:40 == 46.9	11/27/25 4:10 == 47
11/26/25 14:45 == 46.8	11/26/25 19:15 == 46.8	11/26/25 23:45 == 46.8	11/27/25 4:15 == 46.9
11/26/25 14:50 == 46.8	11/26/25 19:20 == 46.9	11/26/25 23:50 == 46.9	11/27/25 4:20 == 46.9
11/26/25 14:55 == 46.9	11/26/25 19:25 == 47	11/26/25 23:55 == 47	11/27/25 4:25 == 47
11/26/25 15:00 == 47	11/26/25 19:30 == 46.9	11/27/25 0:00 == 46.9	11/27/25 4:30 == 46.9
11/26/25 15:05 == 46.8	11/26/25 19:35 == 46.9	11/27/25 0:05 == 46.8	11/27/25 4:35 == 46.8
11/26/25 15:10 == 46.8	11/26/25 19:40 == 46.9	11/27/25 0:10 == 46.8	11/27/25 4:40 == 46.9
11/26/25 15:15 == 46.8	11/26/25 19:45 == 46.9	11/27/25 0:15 == 46.8	11/27/25 4:45 == 46.8
11/26/25 15:20 == 46.8	11/26/25 19:50 == 46.7	11/27/25 0:20 == 46.8	11/27/25 4:50 == 47
11/26/25 15:25 == 46.8	11/26/25 19:55 == 46.8	11/27/25 0:25 == 46.9	11/27/25 4:55 == 46.7

Pumpback Station Discharge (0364)

11/27/25 5:00 == 46.9	11/27/25 9:30 == 46.8	11/27/25 14:00 == 46.9	11/27/25 18:30 == 46.9
11/27/25 5:05 == 46.8	11/27/25 9:35 == 46.6	11/27/25 14:05 == 46.8	11/27/25 18:35 == 46.7
11/27/25 5:10 == 47	11/27/25 9:40 == 46.9	11/27/25 14:10 == 46.9	11/27/25 18:40 == 46.7
11/27/25 5:15 == 46.8	11/27/25 9:45 == 46.9	11/27/25 14:15 == 46.9	11/27/25 18:45 == 46.8
11/27/25 5:20 == 47	11/27/25 9:50 == 46.8	11/27/25 14:20 == 46.9	11/27/25 18:50 == 46.7
11/27/25 5:25 == 47	11/27/25 9:55 == 47	11/27/25 14:25 == 47	11/27/25 18:55 == 46.8
11/27/25 5:30 == 46.9	11/27/25 10:00 == 46.8	11/27/25 14:30 == 46.9	11/27/25 19:00 == 46.9
11/27/25 5:35 == 46.9	11/27/25 10:05 == 47	11/27/25 14:35 == 46.8	11/27/25 19:05 == 46.9
11/27/25 5:40 == 46.8	11/27/25 10:10 == 47	11/27/25 14:40 == 47	11/27/25 19:10 == 46.9
11/27/25 5:45 == 46.9	11/27/25 10:15 == 47	11/27/25 14:45 == 46.7	11/27/25 19:15 == 46.7
11/27/25 5:50 == 46.9	11/27/25 10:20 == 46.8	11/27/25 14:50 == 46.8	11/27/25 19:20 == 46.9
11/27/25 5:55 == 47	11/27/25 10:25 == 46.7	11/27/25 14:55 == 46.8	11/27/25 19:25 == 46.9
11/27/25 6:00 == 46.9	11/27/25 10:30 == 46.7	11/27/25 15:00 == 46.9	11/27/25 19:30 == 46.7
11/27/25 6:05 == 46.9	11/27/25 10:35 == 46.9	11/27/25 15:05 == 46.9	11/27/25 19:35 == 46.7
11/27/25 6:10 == 46.8	11/27/25 10:40 == 46.8	11/27/25 15:10 == 46.8	11/27/25 19:40 == 46.6
11/27/25 6:15 == 46.8	11/27/25 10:45 == 46.8	11/27/25 15:15 == 46.8	11/27/25 19:45 == 46.7
11/27/25 6:20 == 46.9	11/27/25 10:50 == 46.9	11/27/25 15:20 == 47.1	11/27/25 19:50 == 46.7
11/27/25 6:25 == 46.8	11/27/25 10:55 == 46.9	11/27/25 15:25 == 47	11/27/25 19:55 == 46.7
11/27/25 6:30 == 46.7	11/27/25 11:00 == 46.9	11/27/25 15:30 == 46.8	11/27/25 20:00 == 46.7
11/27/25 6:35 == 46.9	11/27/25 11:05 == 46.9	11/27/25 15:35 == 46.8	11/27/25 20:05 == 46.7
11/27/25 6:40 == 46.9	11/27/25 11:10 == 46.9	11/27/25 15:40 == 46.9	11/27/25 20:10 == 46.8
11/27/25 6:45 == 46.8	11/27/25 11:15 == 46.9	11/27/25 15:45 == 46.9	11/27/25 20:15 == 46.8
11/27/25 6:50 == 46.9	11/27/25 11:20 == 46.9	11/27/25 15:50 == 46.9	11/27/25 20:20 == 46.8
11/27/25 6:55 == 46.8	11/27/25 11:25 == 46.9	11/27/25 15:55 == 46.9	11/27/25 20:25 == 46.8
11/27/25 7:00 == 46.8	11/27/25 11:30 == 46.8	11/27/25 16:00 == 47	11/27/25 20:30 == 46.8
11/27/25 7:05 == 46.9	11/27/25 11:35 == 46.7	11/27/25 16:05 == 46.8	11/27/25 20:35 == 47
11/27/25 7:10 == 47	11/27/25 11:40 == 46.7	11/27/25 16:10 == 46.8	11/27/25 20:40 == 47.1
11/27/25 7:15 == 46.8	11/27/25 11:45 == 46.8	11/27/25 16:15 == 46.9	11/27/25 20:45 == 46.9
11/27/25 7:20 == 46.8	11/27/25 11:50 == 46.8	11/27/25 16:20 == 46.8	11/27/25 20:50 == 47.1
11/27/25 7:25 == 47	11/27/25 11:55 == 46.9	11/27/25 16:25 == 47	11/27/25 20:55 == 47.2
11/27/25 7:30 == 47.1	11/27/25 12:00 == 47	11/27/25 16:30 == 46.9	11/27/25 21:00 == 47.3
11/27/25 7:35 == 46.9	11/27/25 12:05 == 46.7	11/27/25 16:35 == 46.9	11/27/25 21:05 == 47.3
11/27/25 7:40 == 46.9	11/27/25 12:10 == 46.8	11/27/25 16:40 == 46.8	11/27/25 21:10 == 46.9
11/27/25 7:45 == 46.9	11/27/25 12:15 == 47.1	11/27/25 16:45 == 46.9	11/27/25 21:15 == 46.9
11/27/25 7:50 == 46.8	11/27/25 12:20 == 46.9	11/27/25 16:50 == 46.7	11/27/25 21:20 == 46.8
11/27/25 7:55 == 46.9	11/27/25 12:25 == 47	11/27/25 16:55 == 46.9	11/27/25 21:25 == 46.8
11/27/25 8:00 == 46.9	11/27/25 12:30 == 46.8	11/27/25 17:00 == 46.8	11/27/25 21:30 == 46.6
11/27/25 8:05 == 46.9	11/27/25 12:35 == 46.8	11/27/25 17:05 == 46.9	11/27/25 21:35 == 46.9
11/27/25 8:10 == 47	11/27/25 12:40 == 46.8	11/27/25 17:10 == 46.9	11/27/25 21:40 == 46.8
11/27/25 8:15 == 46.9	11/27/25 12:45 == 46.8	11/27/25 17:15 == 46.9	11/27/25 21:45 == 46.9
11/27/25 8:20 == 46.9	11/27/25 12:50 == 46.9	11/27/25 17:20 == 46.9	11/27/25 21:50 == 46.9
11/27/25 8:25 == 46.8	11/27/25 12:55 == 47	11/27/25 17:25 == 46.8	11/27/25 21:55 == 46.7
11/27/25 8:30 == 46.9	11/27/25 13:00 == 46.9	11/27/25 17:30 == 46.8	11/27/25 22:00 == 46.8
11/27/25 8:35 == 46.8	11/27/25 13:05 == 46.8	11/27/25 17:35 == 46.7	11/27/25 22:05 == 46.7
11/27/25 8:40 == 46.8	11/27/25 13:10 == 46.9	11/27/25 17:40 == 47	11/27/25 22:10 == 46.9
11/27/25 8:45 == 46.9	11/27/25 13:15 == 47	11/27/25 17:45 == 46.9	11/27/25 22:15 == 46.9
11/27/25 8:50 == 46.7	11/27/25 13:20 == 46.9	11/27/25 17:50 == 47.1	11/27/25 22:20 == 46.9
11/27/25 8:55 == 46.7	11/27/25 13:25 == 46.9	11/27/25 17:55 == 47	11/27/25 22:25 == 47
11/27/25 9:00 == 46.8	11/27/25 13:30 == 46.9	11/27/25 18:00 == 47.1	11/27/25 22:30 == 46.8
11/27/25 9:05 == 46.8	11/27/25 13:35 == 46.9	11/27/25 18:05 == 47.3	11/27/25 22:35 == 46.8
11/27/25 9:10 == 46.8	11/27/25 13:40 == 47	11/27/25 18:10 == 47.3	11/27/25 22:40 == 46.8
11/27/25 9:15 == 46.9	11/27/25 13:45 == 46.9	11/27/25 18:15 == 47.4	11/27/25 22:45 == 46.9
11/27/25 9:20 == 47	11/27/25 13:50 == 46.9	11/27/25 18:20 == 47.1	11/27/25 22:50 == 46.9
11/27/25 9:25 == 46.9	11/27/25 13:55 == 46.9	11/27/25 18:25 == 46.8	11/27/25 22:55 == 46.9

Pumpback Station Discharge (0364)

11/27/25 23:00 == 46.8	11/28/25 3:30 == 46.8	11/28/25 8:00 == 47.2	11/28/25 12:30 == 46.8
11/27/25 23:05 == 46.7	11/28/25 3:35 == 46.9	11/28/25 8:05 == 47.2	11/28/25 12:35 == 46.9
11/27/25 23:10 == 46.8	11/28/25 3:40 == 46.9	11/28/25 8:10 == 47.1	11/28/25 12:40 == 46.9
11/27/25 23:15 == 46.9	11/28/25 3:45 == 46.9	11/28/25 8:15 == 47	11/28/25 12:45 == 46.8
11/27/25 23:20 == 46.8	11/28/25 3:50 == 46.8	11/28/25 8:20 == 46.9	11/28/25 12:50 == 46.8
11/27/25 23:25 == 46.8	11/28/25 3:55 == 46.9	11/28/25 8:25 == 46.8	11/28/25 12:55 == 46.7
11/27/25 23:30 == 46.8	11/28/25 4:00 == 47.3	11/28/25 8:30 == 46.7	11/28/25 13:00 == 46.8
11/27/25 23:35 == 46.7	11/28/25 4:05 == 47.2	11/28/25 8:35 == 46.9	11/28/25 13:05 == 46.8
11/27/25 23:40 == 46.9	11/28/25 4:10 == 47.3	11/28/25 8:40 == 47	11/28/25 13:10 == 46.7
11/27/25 23:45 == 46.9	11/28/25 4:15 == 47.3	11/28/25 8:45 == 47.1	11/28/25 13:15 == 46.7
11/27/25 23:50 == 46.7	11/28/25 4:20 == 47	11/28/25 8:50 == 47.1	11/28/25 13:20 == 46.8
11/27/25 23:55 == 46.9	11/28/25 4:25 == 46.9	11/28/25 8:55 == 47	11/28/25 13:25 == 46.9
11/28/25 0:00 == 46.8	11/28/25 4:30 == 47	11/28/25 9:00 == 47.1	11/28/25 13:30 == 47
11/28/25 0:05 == 46.8	11/28/25 4:35 == 47	11/28/25 9:05 == 47.2	11/28/25 13:35 == 46.9
11/28/25 0:10 == 46.8	11/28/25 4:40 == 46.9	11/28/25 9:10 == 46.9	11/28/25 13:40 == 46.8
11/28/25 0:15 == 47	11/28/25 4:45 == 47	11/28/25 9:15 == 47.1	11/28/25 13:45 == 46.8
11/28/25 0:20 == 46.8	11/28/25 4:50 == 46.9	11/28/25 9:20 == 47.1	11/28/25 13:50 == 46.6
11/28/25 0:25 == 46.8	11/28/25 4:55 == 46.7	11/28/25 9:25 == 47.1	11/28/25 13:55 == 46.8
11/28/25 0:30 == 46.8	11/28/25 5:00 == 46.9	11/28/25 9:30 == 47.1	11/28/25 14:00 == 46.7
11/28/25 0:35 == 47	11/28/25 5:05 == 46.9	11/28/25 9:35 == 47	11/28/25 14:05 == 46.7
11/28/25 0:40 == 47	11/28/25 5:10 == 47	11/28/25 9:40 == 47.1	11/28/25 14:10 == 46.9
11/28/25 0:45 == 47	11/28/25 5:15 == 46.9	11/28/25 9:45 == 47.4	11/28/25 14:15 == 46.8
11/28/25 0:50 == 47	11/28/25 5:20 == 46.8	11/28/25 9:50 == 47.4	11/28/25 14:20 == 46.8
11/28/25 0:55 == 46.8	11/28/25 5:25 == 46.8	11/28/25 9:55 == 47.4	11/28/25 14:25 == 46.7
11/28/25 1:00 == 46.8	11/28/25 5:30 == 46.8	11/28/25 10:00 == 47.6	11/28/25 14:30 == 46.8
11/28/25 1:05 == 47	11/28/25 5:35 == 46.9	11/28/25 10:05 == 47.7	11/28/25 14:35 == 46.8
11/28/25 1:10 == 46.9	11/28/25 5:40 == 46.9	11/28/25 10:10 == 47.4	11/28/25 14:40 == 46.9
11/28/25 1:15 == 46.8	11/28/25 5:45 == 46.9	11/28/25 10:15 == 47.4	11/28/25 14:45 == 46.9
11/28/25 1:20 == 46.8	11/28/25 5:50 == 46.9	11/28/25 10:20 == 47.7	11/28/25 14:50 == 46.9
11/28/25 1:25 == 46.8	11/28/25 5:55 == 46.8	11/28/25 10:25 == 47.7	11/28/25 14:55 == 46.9
11/28/25 1:30 == 46.9	11/28/25 6:00 == 46.8	11/28/25 10:30 == 47.8	11/28/25 15:00 == 46.8
11/28/25 1:35 == 46.9	11/28/25 6:05 == 46.8	11/28/25 10:35 == 47.7	11/28/25 15:05 == 46.8
11/28/25 1:40 == 46.7	11/28/25 6:10 == 46.9	11/28/25 10:40 == 47.7	11/28/25 15:10 == 46.9
11/28/25 1:45 == 46.9	11/28/25 6:15 == 46.9	11/28/25 10:45 == 47.8	11/28/25 15:15 == 46.8
11/28/25 1:50 == 47	11/28/25 6:20 == 46.9	11/28/25 10:50 == 47.8	11/28/25 15:20 == 46.8
11/28/25 1:55 == 46.9	11/28/25 6:25 == 46.8	11/28/25 10:55 == 47.7	11/28/25 15:25 == 46.9
11/28/25 2:00 == 46.8	11/28/25 6:30 == 47	11/28/25 11:00 == 47.8	11/28/25 15:30 == 47
11/28/25 2:05 == 46.8	11/28/25 6:35 == 46.9	11/28/25 11:05 == 47.8	11/28/25 15:35 == 46.9
11/28/25 2:10 == 46.9	11/28/25 6:40 == 46.6	11/28/25 11:10 == 47.7	11/28/25 15:40 == 47
11/28/25 2:15 == 47.1	11/28/25 6:45 == 46.9	11/28/25 11:15 == 47.8	11/28/25 15:45 == 46.8
11/28/25 2:20 == 46.8	11/28/25 6:50 == 46.9	11/28/25 11:20 == 47.5	11/28/25 15:50 == 46.8
11/28/25 2:25 == 47.3	11/28/25 6:55 == 46.9	11/28/25 11:25 == 47.9	11/28/25 15:55 == 47
11/28/25 2:30 == 47.3	11/28/25 7:00 == 47	11/28/25 11:30 == 47.8	11/28/25 16:00 == 46.8
11/28/25 2:35 == 47.5	11/28/25 7:05 == 46.9	11/28/25 11:35 == 47.6	11/28/25 16:05 == 46.9
11/28/25 2:40 == 47.4	11/28/25 7:10 == 47	11/28/25 11:40 == 47.2	11/28/25 16:10 == 46.9
11/28/25 2:45 == 47.3	11/28/25 7:15 == 47.3	11/28/25 11:45 == 47	11/28/25 16:15 == 46.9
11/28/25 2:50 == 47.3	11/28/25 7:20 == 47.5	11/28/25 11:50 == 47	11/28/25 16:20 == 47
11/28/25 2:55 == 46.8	11/28/25 7:25 == 47.4	11/28/25 11:55 == 46.9	11/28/25 16:25 == 46.9
11/28/25 3:00 == 46.9	11/28/25 7:30 == 47.5	11/28/25 12:00 == 46.8	11/28/25 16:30 == 47
11/28/25 3:05 == 46.9	11/28/25 7:35 == 47.5	11/28/25 12:05 == 46.8	11/28/25 16:35 == 46.9
11/28/25 3:10 == 46.8	11/28/25 7:40 == 46.9	11/28/25 12:10 == 46.9	11/28/25 16:40 == 46.8
11/28/25 3:15 == 46.8	11/28/25 7:45 == 46.8	11/28/25 12:15 == 46.9	11/28/25 16:45 == 46.9
11/28/25 3:20 == 46.8	11/28/25 7:50 == 47.2	11/28/25 12:20 == 46.9	11/28/25 16:50 == 46.9
11/28/25 3:25 == 46.7	11/28/25 7:55 == 47.2	11/28/25 12:25 == 46.8	11/28/25 16:55 == 46.9

Pumpback Station Discharge (0364)

11/28/25 17:00 == 47	11/28/25 21:30 == 46.9	11/29/25 2:00 == 46.8	11/29/25 6:30 == 46.9
11/28/25 17:05 == 47	11/28/25 21:35 == 47	11/29/25 2:05 == 46.8	11/29/25 6:35 == 46.8
11/28/25 17:10 == 46.9	11/28/25 21:40 == 46.9	11/29/25 2:10 == 46.8	11/29/25 6:40 == 46.8
11/28/25 17:15 == 46.8	11/28/25 21:45 == 46.9	11/29/25 2:15 == 46.8	11/29/25 6:45 == 46.9
11/28/25 17:20 == 46.9	11/28/25 21:50 == 46.9	11/29/25 2:20 == 46.8	11/29/25 6:50 == 46.9
11/28/25 17:25 == 46.9	11/28/25 21:55 == 46.9	11/29/25 2:25 == 46.8	11/29/25 6:55 == 46.8
11/28/25 17:30 == 46.8	11/28/25 22:00 == 46.9	11/29/25 2:30 == 46.9	11/29/25 7:00 == 46.8
11/28/25 17:35 == 46.8	11/28/25 22:05 == 46.9	11/29/25 2:35 == 46.9	11/29/25 7:05 == 46.8
11/28/25 17:40 == 46.9	11/28/25 22:10 == 46.9	11/29/25 2:40 == 46.8	11/29/25 7:10 == 46.8
11/28/25 17:45 == 47	11/28/25 22:15 == 47	11/29/25 2:45 == 46.8	11/29/25 7:15 == 46.9
11/28/25 17:50 == 46.9	11/28/25 22:20 == 46.9	11/29/25 2:50 == 47	11/29/25 7:20 == 46.9
11/28/25 17:55 == 46.9	11/28/25 22:25 == 46.9	11/29/25 2:55 == 47	11/29/25 7:25 == 46.8
11/28/25 18:00 == 46.9	11/28/25 22:30 == 46.8	11/29/25 3:00 == 46.9	11/29/25 7:30 == 46.8
11/28/25 18:05 == 47	11/28/25 22:35 == 46.8	11/29/25 3:05 == 46.8	11/29/25 7:35 == 46.7
11/28/25 18:10 == 47	11/28/25 22:40 == 47	11/29/25 3:10 == 46.8	11/29/25 7:40 == 46.8
11/28/25 18:15 == 46.8	11/28/25 22:45 == 46.9	11/29/25 3:15 == 46.8	11/29/25 7:45 == 46.7
11/28/25 18:20 == 47	11/28/25 22:50 == 47.1	11/29/25 3:20 == 46.8	11/29/25 7:50 == 46.9
11/28/25 18:25 == 47	11/28/25 22:55 == 46.9	11/29/25 3:25 == 46.6	11/29/25 7:55 == 46.9
11/28/25 18:30 == 46.9	11/28/25 23:00 == 46.9	11/29/25 3:30 == 46.9	11/29/25 8:00 == 47
11/28/25 18:35 == 47	11/28/25 23:05 == 46.9	11/29/25 3:35 == 47.1	11/29/25 8:05 == 46.9
11/28/25 18:40 == 46.9	11/28/25 23:10 == 47	11/29/25 3:40 == 46.9	11/29/25 8:10 == 46.9
11/28/25 18:45 == 46.8	11/28/25 23:15 == 46.9	11/29/25 3:45 == 46.8	11/29/25 8:15 == 46.8
11/28/25 18:50 == 46.9	11/28/25 23:20 == 46.9	11/29/25 3:50 == 46.7	11/29/25 8:20 == 46.8
11/28/25 18:55 == 46.9	11/28/25 23:25 == 47	11/29/25 3:55 == 46.7	11/29/25 8:25 == 47
11/28/25 19:00 == 47	11/28/25 23:30 == 47	11/29/25 4:00 == 46.7	11/29/25 8:30 == 46.9
11/28/25 19:05 == 46.9	11/28/25 23:35 == 46.9	11/29/25 4:05 == 46.9	11/29/25 8:35 == 46.8
11/28/25 19:10 == 46.8	11/28/25 23:40 == 46.8	11/29/25 4:10 == 47	11/29/25 8:40 == 46.7
11/28/25 19:15 == 46.9	11/28/25 23:45 == 46.9	11/29/25 4:15 == 46.9	11/29/25 8:45 == 46.8
11/28/25 19:20 == 47	11/28/25 23:50 == 46.9	11/29/25 4:20 == 46.9	11/29/25 8:50 == 46.8
11/28/25 19:25 == 46.9	11/28/25 23:55 == 46.8	11/29/25 4:25 == 46.9	11/29/25 8:55 == 46.8
11/28/25 19:30 == 46.8	11/29/25 0:00 == 46.9	11/29/25 4:30 == 46.9	11/29/25 9:00 == 46.8
11/28/25 19:35 == 46.8	11/29/25 0:05 == 47	11/29/25 4:35 == 46.8	11/29/25 9:05 == 46.7
11/28/25 19:40 == 46.8	11/29/25 0:10 == 46.9	11/29/25 4:40 == 46.7	11/29/25 9:10 == 46.9
11/28/25 19:45 == 46.9	11/29/25 0:15 == 46.8	11/29/25 4:45 == 46.9	11/29/25 9:15 == 46.8
11/28/25 19:50 == 47	11/29/25 0:20 == 46.7	11/29/25 4:50 == 46.9	11/29/25 9:20 == 46.8
11/28/25 19:55 == 46.9	11/29/25 0:25 == 46.8	11/29/25 4:55 == 46.8	11/29/25 9:25 == 46.9
11/28/25 20:00 == 47.1	11/29/25 0:30 == 46.9	11/29/25 5:00 == 46.9	11/29/25 9:30 == 46.9
11/28/25 20:05 == 47	11/29/25 0:35 == 47.1	11/29/25 5:05 == 47	11/29/25 9:35 == 46.7
11/28/25 20:10 == 46.8	11/29/25 0:40 == 47	11/29/25 5:10 == 47	11/29/25 9:40 == 46.8
11/28/25 20:15 == 46.8	11/29/25 0:45 == 47	11/29/25 5:15 == 46.9	11/29/25 9:45 == 47
11/28/25 20:20 == 47	11/29/25 0:50 == 47.1	11/29/25 5:20 == 46.9	11/29/25 9:50 == 47
11/28/25 20:25 == 46.8	11/29/25 0:55 == 46.8	11/29/25 5:25 == 46.8	11/29/25 9:55 == 47
11/28/25 20:30 == 46.9	11/29/25 1:00 == 46.8	11/29/25 5:30 == 46.8	11/29/25 10:00 == 47
11/28/25 20:35 == 46.9	11/29/25 1:05 == 46.8	11/29/25 5:35 == 46.8	11/29/25 10:05 == 46.9
11/28/25 20:40 == 47	11/29/25 1:10 == 46.9	11/29/25 5:40 == 46.7	11/29/25 10:10 == 47
11/28/25 20:45 == 46.9	11/29/25 1:15 == 46.8	11/29/25 5:45 == 46.7	11/29/25 10:15 == 47
11/28/25 20:50 == 47	11/29/25 1:20 == 46.8	11/29/25 5:50 == 46.9	11/29/25 10:20 == 46.8
11/28/25 20:55 == 47.1	11/29/25 1:25 == 47	11/29/25 5:55 == 47.1	11/29/25 10:25 == 46.8
11/28/25 21:00 == 47	11/29/25 1:30 == 47	11/29/25 6:00 == 46.9	11/29/25 10:30 == 46.8
11/28/25 21:05 == 47	11/29/25 1:35 == 46.9	11/29/25 6:05 == 46.9	11/29/25 10:35 == 46.8
11/28/25 21:10 == 47	11/29/25 1:40 == 46.9	11/29/25 6:10 == 46.7	11/29/25 10:40 == 46.9
11/28/25 21:15 == 46.9	11/29/25 1:45 == 46.9	11/29/25 6:15 == 46.9	11/29/25 10:45 == 47
11/28/25 21:20 == 47	11/29/25 1:50 == 46.9	11/29/25 6:20 == 46.8	11/29/25 10:50 == 46.8
11/28/25 21:25 == 46.8	11/29/25 1:55 == 46.9	11/29/25 6:25 == 46.9	11/29/25 10:55 == 46.9

Pumpback Station Discharge (0364)

11/29/25 11:00 == 46.9	11/29/25 15:30 == 46.8	11/29/25 20:00 == 46.6	11/30/25 0:30 == 46.7
11/29/25 11:05 == 46.9	11/29/25 15:35 == 46.7	11/29/25 20:05 == 46.6	11/30/25 0:35 == 46.7
11/29/25 11:10 == 46.9	11/29/25 15:40 == 46.9	11/29/25 20:10 == 46.7	11/30/25 0:40 == 46.5
11/29/25 11:15 == 46.7	11/29/25 15:45 == 46.8	11/29/25 20:15 == 46.6	11/30/25 0:45 == 46.6
11/29/25 11:20 == 46.8	11/29/25 15:50 == 46.8	11/29/25 20:20 == 46.6	11/30/25 0:50 == 46.7
11/29/25 11:25 == 47	11/29/25 15:55 == 46.7	11/29/25 20:25 == 46.7	11/30/25 0:55 == 46.6
11/29/25 11:30 == 47	11/29/25 16:00 == 46.8	11/29/25 20:30 == 46.6	11/30/25 1:00 == 46.7
11/29/25 11:35 == 46.9	11/29/25 16:05 == 46.7	11/29/25 20:35 == 46.7	11/30/25 1:05 == 46.6
11/29/25 11:40 == 46.9	11/29/25 16:10 == 46.8	11/29/25 20:40 == 46.8	11/30/25 1:10 == 46.6
11/29/25 11:45 == 46.9	11/29/25 16:15 == 46.9	11/29/25 20:45 == 46.7	11/30/25 1:15 == 46.6
11/29/25 11:50 == 46.9	11/29/25 16:20 == 46.9	11/29/25 20:50 == 46.7	11/30/25 1:20 == 46.7
11/29/25 11:55 == 46.8	11/29/25 16:25 == 46.8	11/29/25 20:55 == 46.7	11/30/25 1:25 == 46.8
11/29/25 12:00 == 46.8	11/29/25 16:30 == 46.8	11/29/25 21:00 == 46.7	11/30/25 1:30 == 46.8
11/29/25 12:05 == 46.8	11/29/25 16:35 == 46.8	11/29/25 21:05 == 46.8	11/30/25 1:35 == 46.7
11/29/25 12:10 == 46.9	11/29/25 16:40 == 46.8	11/29/25 21:10 == 46.7	11/30/25 1:40 == 46.7
11/29/25 12:15 == 46.8	11/29/25 16:45 == 46.8	11/29/25 21:15 == 46.6	11/30/25 1:45 == 46.8
11/29/25 12:20 == 46.8	11/29/25 16:50 == 46.9	11/29/25 21:20 == 46.6	11/30/25 1:50 == 46.7
11/29/25 12:25 == 46.8	11/29/25 16:55 == 46.8	11/29/25 21:25 == 46.8	11/30/25 1:55 == 46.5
11/29/25 12:30 == 46.8	11/29/25 17:00 == 46.7	11/29/25 21:30 == 46.7	11/30/25 2:00 == 46.6
11/29/25 12:35 == 46.9	11/29/25 17:05 == 46.7	11/29/25 21:35 == 46.6	11/30/25 2:05 == 46.7
11/29/25 12:40 == 46.9	11/29/25 17:10 == 46.8	11/29/25 21:40 == 46.6	11/30/25 2:10 == 46.6
11/29/25 12:45 == 46.8	11/29/25 17:15 == 46.6	11/29/25 21:45 == 46.6	11/30/25 2:15 == 46.7
11/29/25 12:50 == 46.7	11/29/25 17:20 == 46.8	11/29/25 21:50 == 46.7	11/30/25 2:20 == 46.8
11/29/25 12:55 == 46.6	11/29/25 17:25 == 46.8	11/29/25 21:55 == 46.7	11/30/25 2:25 == 46.8
11/29/25 13:00 == 47	11/29/25 17:30 == 46.8	11/29/25 22:00 == 46.8	11/30/25 2:30 == 46.7
11/29/25 13:05 == 46.9	11/29/25 17:35 == 46.8	11/29/25 22:05 == 46.5	11/30/25 2:35 == 46.7
11/29/25 13:10 == 46.9	11/29/25 17:40 == 46.8	11/29/25 22:10 == 46.8	11/30/25 2:40 == 46.7
11/29/25 13:15 == 46.8	11/29/25 17:45 == 46.8	11/29/25 22:15 == 46.8	11/30/25 2:45 == 46.6
11/29/25 13:20 == 46.9	11/29/25 17:50 == 46.9	11/29/25 22:20 == 46.7	11/30/25 2:50 == 46.6
11/29/25 13:25 == 46.8	11/29/25 17:55 == 46.9	11/29/25 22:25 == 46.8	11/30/25 2:55 == 46.8
11/29/25 13:30 == 46.9	11/29/25 18:00 == 46.7	11/29/25 22:30 == 46.7	11/30/25 3:00 == 46.7
11/29/25 13:35 == 46.8	11/29/25 18:05 == 46.7	11/29/25 22:35 == 46.7	11/30/25 3:05 == 46.7
11/29/25 13:40 == 46.9	11/29/25 18:10 == 46.9	11/29/25 22:40 == 46.7	11/30/25 3:10 == 46.6
11/29/25 13:45 == 47	11/29/25 18:15 == 46.7	11/29/25 22:45 == 46.8	11/30/25 3:15 == 46.6
11/29/25 13:50 == 46.9	11/29/25 18:20 == 46.7	11/29/25 22:50 == 46.7	11/30/25 3:20 == 46.7
11/29/25 13:55 == 47	11/29/25 18:25 == 46.7	11/29/25 22:55 == 46.6	11/30/25 3:25 == 46.7
11/29/25 14:00 == 46.9	11/29/25 18:30 == 46.7	11/29/25 23:00 == 46.7	11/30/25 3:30 == 46.7
11/29/25 14:05 == 46.8	11/29/25 18:35 == 46.7	11/29/25 23:05 == 46.8	11/30/25 3:35 == 46.6
11/29/25 14:10 == 46.8	11/29/25 18:40 == 46.6	11/29/25 23:10 == 46.7	11/30/25 3:40 == 46.7
11/29/25 14:15 == 46.7	11/29/25 18:45 == 46.6	11/29/25 23:15 == 46.7	11/30/25 3:45 == 46.6
11/29/25 14:20 == 46.7	11/29/25 18:50 == 46.7	11/29/25 23:20 == 46.8	11/30/25 3:50 == 46.7
11/29/25 14:25 == 46.6	11/29/25 18:55 == 46.6	11/29/25 23:25 == 46.7	11/30/25 3:55 == 46.7
11/29/25 14:30 == 46.6	11/29/25 19:00 == 46.6	11/29/25 23:30 == 46.6	11/30/25 4:00 == 46.7
11/29/25 14:35 == 46.9	11/29/25 19:05 == 46.7	11/29/25 23:35 == 46.7	11/30/25 4:05 == 46.7
11/29/25 14:40 == 46.9	11/29/25 19:10 == 46.7	11/29/25 23:40 == 46.6	11/30/25 4:10 == 46.7
11/29/25 14:45 == 46.7	11/29/25 19:15 == 46.7	11/29/25 23:45 == 46.6	11/30/25 4:15 == 46.6
11/29/25 14:50 == 46.8	11/29/25 19:20 == 46.7	11/29/25 23:50 == 46.6	11/30/25 4:20 == 46.7
11/29/25 14:55 == 46.8	11/29/25 19:25 == 46.6	11/29/25 23:55 == 46.6	11/30/25 4:25 == 46.7
11/29/25 15:00 == 46.9	11/29/25 19:30 == 46.9	11/30/25 0:00 == 46.7	11/30/25 4:30 == 46.7
11/29/25 15:05 == 46.8	11/29/25 19:35 == 46.6	11/30/25 0:05 == 46.8	11/30/25 4:35 == 46.6
11/29/25 15:10 == 46.7	11/29/25 19:40 == 46.7	11/30/25 0:10 == 46.6	11/30/25 4:40 == 46.6
11/29/25 15:15 == 46.9	11/29/25 19:45 == 46.6	11/30/25 0:15 == 46.8	11/30/25 4:45 == 46.7
11/29/25 15:20 == 46.8	11/29/25 19:50 == 46.8	11/30/25 0:20 == 46.6	11/30/25 4:50 == 46.4
11/29/25 15:25 == 46.7	11/29/25 19:55 == 46.8	11/30/25 0:25 == 46.6	11/30/25 4:55 == 46.6

Pumpback Station Discharge (0364)

11/30/25 5:00 == 46.7	11/30/25 9:30 == 46.6	11/30/25 14:00 == 46.4	11/30/25 18:30 == 46.6
11/30/25 5:05 == 46.7	11/30/25 9:35 == 46.5	11/30/25 14:05 == 46.6	11/30/25 18:35 == 46.6
11/30/25 5:10 == 46.6	11/30/25 9:40 == 46.5	11/30/25 14:10 == 46.7	11/30/25 18:40 == 46.6
11/30/25 5:15 == 46.6	11/30/25 9:45 == 46.6	11/30/25 14:15 == 46.7	11/30/25 18:45 == 46.6
11/30/25 5:20 == 46.7	11/30/25 9:50 == 46.7	11/30/25 14:20 == 46.7	11/30/25 18:50 == 46.8
11/30/25 5:25 == 46.9	11/30/25 9:55 == 46.6	11/30/25 14:25 == 46.6	11/30/25 18:55 == 46.8
11/30/25 5:30 == 46.5	11/30/25 10:00 == 46.8	11/30/25 14:30 == 46.7	11/30/25 19:00 == 46.8
11/30/25 5:35 == 46.6	11/30/25 10:05 == 46.7	11/30/25 14:35 == 46.7	11/30/25 19:05 == 46.6
11/30/25 5:40 == 46.7	11/30/25 10:10 == 46.6	11/30/25 14:40 == 46.5	11/30/25 19:10 == 46.6
11/30/25 5:45 == 46.7	11/30/25 10:15 == 46.7	11/30/25 14:45 == 46.7	11/30/25 19:15 == 46.9
11/30/25 5:50 == 46.7	11/30/25 10:20 == 46.5	11/30/25 14:50 == 46.5	11/30/25 19:20 == 46.8
11/30/25 5:55 == 46.7	11/30/25 10:25 == 46.6	11/30/25 14:55 == 46.6	11/30/25 19:25 == 46.8
11/30/25 6:00 == 46.8	11/30/25 10:30 == 46.6	11/30/25 15:00 == 46.4	11/30/25 19:30 == 46.6
11/30/25 6:05 == 46.8	11/30/25 10:35 == 46.5	11/30/25 15:05 == 46.5	11/30/25 19:35 == 46.7
11/30/25 6:10 == 46.6	11/30/25 10:40 == 46.6	11/30/25 15:10 == 46.6	11/30/25 19:40 == 46.7
11/30/25 6:15 == 46.6	11/30/25 10:45 == 46.6	11/30/25 15:15 == 46.6	11/30/25 19:45 == 46.8
11/30/25 6:20 == 46.7	11/30/25 10:50 == 46.6	11/30/25 15:20 == 46.6	11/30/25 19:50 == 46.7
11/30/25 6:25 == 46.7	11/30/25 10:55 == 46.7	11/30/25 15:25 == 46.6	11/30/25 19:55 == 46.7
11/30/25 6:30 == 46.5	11/30/25 11:00 == 46.6	11/30/25 15:30 == 46.6	11/30/25 20:00 == 46.8
11/30/25 6:35 == 46.7	11/30/25 11:05 == 46.6	11/30/25 15:35 == 46.5	11/30/25 20:05 == 46.8
11/30/25 6:40 == 46.6	11/30/25 11:10 == 46.7	11/30/25 15:40 == 46.6	11/30/25 20:10 == 46.8
11/30/25 6:45 == 46.6	11/30/25 11:15 == 46.7	11/30/25 15:45 == 46.7	11/30/25 20:15 == 46.8
11/30/25 6:50 == 46.6	11/30/25 11:20 == 46.7	11/30/25 15:50 == 46.8	11/30/25 20:20 == 46.7
11/30/25 6:55 == 46.6	11/30/25 11:25 == 46.6	11/30/25 15:55 == 46.6	11/30/25 20:25 == 46.8
11/30/25 7:00 == 46.6	11/30/25 11:30 == 46.7	11/30/25 16:00 == 46.5	11/30/25 20:30 == 46.8
11/30/25 7:05 == 46.6	11/30/25 11:35 == 46.9	11/30/25 16:05 == 46.8	11/30/25 20:35 == 46.7
11/30/25 7:10 == 46.5	11/30/25 11:40 == 46.6	11/30/25 16:10 == 46.9	11/30/25 20:40 == 46.8
11/30/25 7:15 == 46.7	11/30/25 11:45 == 46.8	11/30/25 16:15 == 46.9	11/30/25 20:45 == 46.7
11/30/25 7:20 == 46.6	11/30/25 11:50 == 46.7	11/30/25 16:20 == 46.7	11/30/25 20:50 == 46.7
11/30/25 7:25 == 46.6	11/30/25 11:55 == 46.8	11/30/25 16:25 == 46.6	11/30/25 20:55 == 46.6
11/30/25 7:30 == 46.6	11/30/25 12:00 == 46.7	11/30/25 16:30 == 46.5	11/30/25 21:00 == 46.5
11/30/25 7:35 == 46.7	11/30/25 12:05 == 46.7	11/30/25 16:35 == 46.7	11/30/25 21:05 == 46.7
11/30/25 7:40 == 46.6	11/30/25 12:10 == 46.7	11/30/25 16:40 == 46.6	11/30/25 21:10 == 46.7
11/30/25 7:45 == 46.6	11/30/25 12:15 == 46.8	11/30/25 16:45 == 46.8	11/30/25 21:15 == 46.7
11/30/25 7:50 == 46.7	11/30/25 12:20 == 46.9	11/30/25 16:50 == 46.8	11/30/25 21:20 == 46.6
11/30/25 7:55 == 46.5	11/30/25 12:25 == 46.7	11/30/25 16:55 == 46.8	11/30/25 21:25 == 46.7
11/30/25 8:00 == 46.6	11/30/25 12:30 == 46.6	11/30/25 17:00 == 46.9	11/30/25 21:30 == 46.7
11/30/25 8:05 == 46.7	11/30/25 12:35 == 46.7	11/30/25 17:05 == 46.7	11/30/25 21:35 == 46.8
11/30/25 8:10 == 46.6	11/30/25 12:40 == 46.7	11/30/25 17:10 == 46.8	11/30/25 21:40 == 46.9
11/30/25 8:15 == 46.7	11/30/25 12:45 == 46.6	11/30/25 17:15 == 46.8	11/30/25 21:45 == 46.8
11/30/25 8:20 == 46.8	11/30/25 12:50 == 46.8	11/30/25 17:20 == 46.8	11/30/25 21:50 == 46.7
11/30/25 8:25 == 46.7	11/30/25 12:55 == 46.8	11/30/25 17:25 == 46.9	11/30/25 21:55 == 46.7
11/30/25 8:30 == 46.7	11/30/25 13:00 == 46.6	11/30/25 17:30 == 46.7	11/30/25 22:00 == 46.7
11/30/25 8:35 == 46.6	11/30/25 13:05 == 46.7	11/30/25 17:35 == 46.9	11/30/25 22:05 == 46.7
11/30/25 8:40 == 46.6	11/30/25 13:10 == 46.7	11/30/25 17:40 == 46.9	11/30/25 22:10 == 46.9
11/30/25 8:45 == 46.5	11/30/25 13:15 == 46.7	11/30/25 17:45 == 46.8	11/30/25 22:15 == 46.8
11/30/25 8:50 == 46.5	11/30/25 13:20 == 46.8	11/30/25 17:50 == 46.8	11/30/25 22:20 == 46.8
11/30/25 8:55 == 46.6	11/30/25 13:25 == 46.8	11/30/25 17:55 == 46.9	11/30/25 22:25 == 46.6
11/30/25 9:00 == 46.7	11/30/25 13:30 == 46.8	11/30/25 18:00 == 46.8	11/30/25 22:30 == 46.6
11/30/25 9:05 == 46.7	11/30/25 13:35 == 46.7	11/30/25 18:05 == 46.8	11/30/25 22:35 == 46.7
11/30/25 9:10 == 46.7	11/30/25 13:40 == 46.7	11/30/25 18:10 == 46.9	11/30/25 22:40 == 46.7
11/30/25 9:15 == 46.6	11/30/25 13:45 == 46.8	11/30/25 18:15 == 46.7	11/30/25 22:45 == 46.7
11/30/25 9:20 == 46.7	11/30/25 13:50 == 46.9	11/30/25 18:20 == 46.9	11/30/25 22:50 == 46.7
11/30/25 9:25 == 46.6	11/30/25 13:55 == 46.7	11/30/25 18:25 == 46.8	11/30/25 22:55 == 43.1

Pumpback Station Discharge (0364)

11/30/25 23:00 == 34.7
11/30/25 23:05 == 31.9
11/30/25 23:10 == 31.7
11/30/25 23:15 == 31.7
11/30/25 23:20 == 31.7
11/30/25 23:25 == 33.2
11/30/25 23:30 == 43.5
11/30/25 23:35 == 47
11/30/25 23:40 == 47.1
11/30/25 23:45 == 46.8
11/30/25 23:50 == 46.9
11/30/25 23:55 == 46.8