

LORP Synopsis for July 2015

Compliance Comments:

Flows were above the minimum flow for the month.

Maintenance

Activities for the month on the Lower Owens River included the following:

- Current metering continues the development of discharge curves at all in-river flow monitoring sites and are used to develop velocity indexing tables.
- Some in-river station measurements have fluctuated as a result of shifting and increased sedimentation in the river, requiring additional indexing to increase the accuracy of measurements.

Operations

Here are the flow changes during the month:

LORP Intake from 60 cfs to 75 cfs on July 1st, 2015

LORP Intake from 75 cfs to 70 cfs on July 7th, 2015

LORP Intake from 70 cfs to 60 cfs on July 14th, 2015

Locust Ditch Return to LOR from 0 cfs to 5 cfs on July 15th, 2015

Locust Ditch Return to LOR from 5 cfs to 10 cfs on July 20th, 2015

Georges Ditch Return to LOR from 1 cfs to 8 cfs on July 2nd, 2015

Georges Ditch Return to LOR from 10 cfs to 5 cfs on July 9th, 2015

Georges Ditch Return to LOR from 5 cfs to 10 cfs on July 14th, 2015

Georges Ditch Return to LOR from 10 cfs to 5 cfs on July 20th, 2015

Alabama Gates Release from 15 cfs to 0 cfs on July 6th, 2015

Waterfowl Area Monthly Report

Synopsis (for Runoff Year 2015-16)

The runoff forecast for runoff year 2015-16 is 36%, so the waterfowl acreage goal for this year is 180 acres.

On April 1st, 2015 the Thibaut Waterfowl Area inflow was reduced to 0 cfs, the Drew Slough Waterfowl Area was reduced to 0 cfs and the Winterton Waterfowl Area inflows were turned on to 6.6 cfs.

On May 1st, 2015 the flows to the Winterton area were reduced to 5.6 CFS.

On May 6th, 2015 the wetted perimeter was measured with GPS. The wetted area for the middle of the spring season was measured to be 235 acres for Drew Slough and Winterton was measured to have an area of 86 acres.

On June 1st, 2015 the flows to the Winterton area were increased to 6.0 CFS.

Drew Unit

<u>Inflow</u>	<u>Date Set</u>	<u>Wetted Acreage</u>	<u>Date of GPS</u>
0 cfs	4/1/15	235	5/6/14

Waggoner Unit

<u>Inflow</u>	<u>Date Set</u>	<u>Wetted Acreage</u>	<u>Date of GPS</u>
N/A		N/A	

Winterton Unit

<u>Inflow</u>	<u>Date Set</u>	<u>Wetted Acreage</u>	<u>Date of GPS</u>
6.6 cfs	4/1/15	86	5/6/15
5.6 cfs	5/1/15		
6.0 cfs	6/1/15		

Thibaut Unit

<u>Inflow</u>	<u>Date Set</u>	<u>Wetted Acreage</u>	<u>Date of GPS</u>
0	4/1/15	N/A	

July 2015 IN-RIVER STATION CURRENT METERING SUMMARY

Station	Date	Metered Flow	Station Begin Flow	Station End Flow	Shift Applied	Notes
LORP Intake	7/22/2015	60.12	59.6	59.6	0	gage height 5.41
At Mazourka Canyon Road	7/22/2015	49.63	52.63	54.37	-4	gage height 4.30
At Reinhackle Springs	7/22/2015	63.95	73.32	68.67	-7	gage height 4.59

Month: July
Year: 2015

Date	Intake			Blackrock Ditch Return		Goose Lake Return		Billy Lake Return		Mazourka Canyon Road			Locust Ditch Return		Georges Ditch Return		Reinhackle Springs			Alabama Gates Release		Above Pumpstation			Pumpback Discharge		Lange-mann Release to Delta	Weir to Delta	River Daily Avg
	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Avg Flow	15 Day Avg	# Days of last 15 at 40+ cfs	Daily Flow	Avg Month to Date					
07/01/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/02/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/03/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/04/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/05/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/06/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/07/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/08/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/09/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/10/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/11/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/12/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/13/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/14/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/15/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/16/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/17/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/18/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/19/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/20/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/21/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/22/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/23/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/24/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/25/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/26/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/27/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/28/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/29/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/30/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48
07/31/15	49	48	15	1	1	1	1	0.8	1	49	45	15	0	0	0	0	48	43	15	0	0	46	47	15	42	42	4	0	48

Lower Owens River Project Flow Report for 07/01/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			67	58	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			48	47	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	1	11			
Reinhackle Springs			46	51	15
Alabama Gates Return (augmentation)	16	5			
At Pumpback Station ¹			32	39	7
Pump Station			28	34	
Langemann Gate to Delta			4	5	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			48	49	

Pump Station Month-to-Date Average Flow 28 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.33 ft	(Last Collected: 6/18/2015)
Lower Twin Lake Gage Read	2.1 ft	
Goose Lake Gage Read	2.48 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/02/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			78	59	15
Blackrock Ditch Return (augmentation)	0.5	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			50	47	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	4	10			
Reinhackle Springs			45	51	15
Alabama Gates Return (augmentation)	29	6			
At Pumpback Station ¹			42	39	7
Pump Station			30	33	
Langemann Gate to Delta			6	5	
Weir to Delta			6	0	
LORP In Channel Average Flow ²			54	49	

Pump Station Month-to-Date Average Flow 29 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.33 ft	(Last Collected: 6/18/2015)
Lower Twin Lake Gage Read	2.1 ft	
Goose Lake Gage Read	2.48 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/03/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			78	60	15
Blackrock Ditch Return (augmentation)	0.5	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			51	48	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	10	10			
Reinhackle Springs			52	51	15
Alabama Gates Return (augmentation)	22	7			
At Pumpback Station ¹			40	39	8
Pump Station			30	33	
Langemann Gate to Delta			10	5	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			55	49	

Pump Station Month-to-Date Average Flow 29 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.33 ft	(Last Collected: 6/18/2015)
Lower Twin Lake Gage Read	2.1 ft	
Goose Lake Gage Read	2.48 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/04/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			77	62	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			53	48	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	10	10			
Reinhackle Springs			53	51	15
Alabama Gates Return (augmentation)	15	7			
At Pumpback Station ¹			41	39	9
Pump Station			31	33	
Langemann Gate to Delta			10	5	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	50	

Pump Station Month-to-Date Average Flow 30 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.33 ft	(Last Collected: 6/18/2015)
Lower Twin Lake Gage Read	2.1 ft	
Goose Lake Gage Read	2.48 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/05/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			75	63	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			56	49	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	9	10			
Reinhackle Springs			56	52	15
Alabama Gates Return (augmentation)	19	8			
At Pumpback Station ¹			43	39	9
Pump Station			33	33	
Langemann Gate to Delta			10	5	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			58	51	

Pump Station Month-to-Date Average Flow 30 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.33 ft	(Last Collected: 6/18/2015)
Lower Twin Lake Gage Read	2.1 ft	
Goose Lake Gage Read	2.48 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/06/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			75	64	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			60	49	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	10	10			
Reinhackle Springs			57	52	15
Alabama Gates Return (augmentation)	7	8			
At Pumpback Station ¹			47	39	9
Pump Station			37	33	
Langemann Gate to Delta			10	6	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			60	51	

Pump Station Month-to-Date Average Flow 32 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.44 ft	(Last Collected: 7/2/2015)
Lower Twin Lake Gage Read	2.26 ft	
Goose Lake Gage Read	2.54 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/07/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			72	65	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			62	50	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	11	10			
Reinhackle Springs			58	53	15
Alabama Gates Return (augmentation)	0	7			
At Pumpback Station ¹			47	40	9
Pump Station			42	34	
Langemann Gate to Delta			5	5	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			60	52	

Pump Station Month-to-Date Average Flow 33 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.44 ft	(Last Collected: 7/2/2015)
Lower Twin Lake Gage Read	2.26 ft	
Goose Lake Gage Read	2.54 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/08/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			69	66	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.4	1			
Mazourka Canyon Road			63	51	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	11	10			
Reinhackle Springs			60	54	15
Alabama Gates Return (augmentation)	0	7			
At Pumpback Station ¹			48	40	9
Pump Station			45	35	
Langemann Gate to Delta			3	5	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			60	53	

Pump Station Month-to-Date Average Flow 35 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.44 ft	(Last Collected: 7/2/2015)
Lower Twin Lake Gage Read	2.26 ft	
Goose Lake Gage Read	2.54 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/09/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			69	67	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.4	1			
Mazourka Canyon Road			64	52	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	9	9			
Reinhackle Springs			63	54	15
Alabama Gates Return (augmentation)	0	7			
At Pumpback Station ¹			49	41	9
Pump Station			46	35	
Langemann Gate to Delta			3	5	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			61	53	

Pump Station Month-to-Date Average Flow 36 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.44 ft	(Last Collected: 7/2/2015)
Lower Twin Lake Gage Read	2.26 ft	
Goose Lake Gage Read	2.54 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/10/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			69	68	15
Blackrock Ditch Return (augmentation)	1.3	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.4	1			
Mazourka Canyon Road			64	53	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	5	9			
Reinhackle Springs			63	55	15
Alabama Gates Return (augmentation)	0	7			
At Pumpback Station ¹			46	41	9
Pump Station			43	36	
Langemann Gate to Delta			3	5	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			61	54	

Pump Station Month-to-Date Average Flow 37 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.44 ft	(Last Collected: 7/2/2015)
Lower Twin Lake Gage Read	2.26 ft	
Goose Lake Gage Read	2.54 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/11/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			70	69	15
Blackrock Ditch Return (augmentation)	1.3	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			64	55	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	5	9			
Reinhackle Springs			61	56	15
Alabama Gates Return (augmentation)	0	7			
At Pumpback Station ¹			40	41	10
Pump Station			37	36	
Langemann Gate to Delta			3	5	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			59	55	

Pump Station Month-to-Date Average Flow 37 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.44 ft	(Last Collected: 7/2/2015)
Lower Twin Lake Gage Read	2.26 ft	
Goose Lake Gage Read	2.54 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/12/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			70	70	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			62	56	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	6	8			
Reinhackle Springs			63	56	15
Alabama Gates Return (augmentation)	8	8			
At Pumpback Station ¹			44	42	11
Pump Station			40	36	
Langemann Gate to Delta			3	5	
Weir to Delta			1	0	
LORP In Channel Average Flow ²			60	56	

Pump Station Month-to-Date Average Flow 37 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.44 ft	(Last Collected: 7/2/2015)
Lower Twin Lake Gage Read	2.26 ft	
Goose Lake Gage Read	2.54 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/13/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			70	71	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.3	1			
Mazourka Canyon Road			61	57	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	6	8			
Reinhackle Springs			64	57	15
Alabama Gates Return (augmentation)	0	8			
At Pumpback Station ¹			43	42	12
Pump Station			40	37	
Langemann Gate to Delta			3	5	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			60	57	

Pump Station Month-to-Date Average Flow 37 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.44 ft	(Last Collected: 7/2/2015)
Lower Twin Lake Gage Read	2.26 ft	
Goose Lake Gage Read	2.54 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/14/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			64	71	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.2	1			
Mazourka Canyon Road			60	58	15
Locust Ditch Return (augmentation)	0	0			
Georges Ditch Return (augmentation)	8	8			
Reinhackle Springs			65	57	15
Alabama Gates Return (augmentation)	0	8			
At Pumpback Station ¹			43	43	13
Pump Station			40	37	
Langemann Gate to Delta			3	5	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			58	57	

Pump Station Month-to-Date Average Flow 37 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.44 ft	(Last Collected: 7/2/2015)
Lower Twin Lake Gage Read	2.26 ft	
Goose Lake Gage Read	2.54 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.

2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.

3. Thibaut and Waggoner Water Areas are currently off.

Note - All Data shown in this report is from field electronic measuring and data collection devices.

Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:

<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/15/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			58	71	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			59	58	15
Locust Ditch Return (augmentation)	1	0			
Georges Ditch Return (augmentation)	11	8			
Reinhackle Springs			69	58	15
Alabama Gates Return (augmentation)	0	8			
At Pumpback Station ¹			42	43	14
Pump Station			39	37	
Langemann Gate to Delta			3	5	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			57	57	

Pump Station Month-to-Date Average Flow 37 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.36 ft	(Last Collected: 7/15/2015)
Lower Twin Lake Gage Read	2.1 ft	
Goose Lake Gage Read	2.5 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/16/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			58	70	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			58	59	15
Locust Ditch Return (augmentation)	5	0			
Georges Ditch Return (augmentation)	10	8			
Reinhackle Springs			69	60	15
Alabama Gates Return (augmentation)	0	7			
At Pumpback Station ¹			41	44	15
Pump Station			38	38	
Langemann Gate to Delta			3	5	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			57	58	

Pump Station Month-to-Date Average Flow 37 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.36 ft	(Last Collected: 7/15/2015)
Lower Twin Lake Gage Read	2.1 ft	
Goose Lake Gage Read	2.5 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/17/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			58	69	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	0.9	1			
Mazourka Canyon Road			57	60	15
Locust Ditch Return (augmentation)	8	1			
Georges Ditch Return (augmentation)	9	9			
Reinhackle Springs			67	61	15
Alabama Gates Return (augmentation)	0	5			
At Pumpback Station ¹			42	44	15
Pump Station			39	39	
Langemann Gate to Delta			3	5	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	59	

Pump Station Month-to-Date Average Flow 38 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.36 ft	(Last Collected: 7/15/2015)
Lower Twin Lake Gage Read	2.1 ft	
Goose Lake Gage Read	2.5 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/18/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			58	67	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	0.8	1			
Mazourka Canyon Road			54	60	15
Locust Ditch Return (augmentation)	7	1			
Georges Ditch Return (augmentation)	8	9			
Reinhackle Springs			65	62	15
Alabama Gates Return (augmentation)	0	3			
At Pumpback Station ¹			42	44	15
Pump Station			39	39	
Langemann Gate to Delta			3	5	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			55	58	

Pump Station Month-to-Date Average Flow 38 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.36 ft	(Last Collected: 7/15/2015)
Lower Twin Lake Gage Read	2.1 ft	
Goose Lake Gage Read	2.5 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/19/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			60	66	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	0.7	1			
Mazourka Canyon Road			52	60	15
Locust Ditch Return (augmentation)	8	2			
Georges Ditch Return (augmentation)	8	8			
Reinhackle Springs			69	63	15
Alabama Gates Return (augmentation)	0	2			
At Pumpback Station ¹			43	44	15
Pump Station			40	40	
Langemann Gate to Delta			3	4	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			56	58	

Pump Station Month-to-Date Average Flow 38 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.36 ft	(Last Collected: 7/15/2015)
Lower Twin Lake Gage Read	2.1 ft	
Goose Lake Gage Read	2.5 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/20/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			60	65	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	0.7	1			
Mazourka Canyon Road			51	59	15
Locust Ditch Return (augmentation)	8	2			
Georges Ditch Return (augmentation)	9	8			
Reinhackle Springs			75	65	15
Alabama Gates Return (augmentation)	0	1			
At Pumpback Station ¹			45	44	15
Pump Station			42	40	
Langemann Gate to Delta			3	4	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			58	58	

Pump Station Month-to-Date Average Flow 38 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.36 ft	(Last Collected: 7/15/2015)
Lower Twin Lake Gage Read	2.1 ft	
Goose Lake Gage Read	2.5 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/21/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			60	64	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	0.9	1			
Mazourka Canyon Road			51	59	15
Locust Ditch Return (augmentation)	8	3			
Georges Ditch Return (augmentation)	6	8			
Reinhackle Springs			73	66	15
Alabama Gates Return (augmentation)	0	1			
At Pumpback Station ¹			45	44	15
Pump Station			41	41	
Langemann Gate to Delta			3	3	
Weir to Delta			1	0	
LORP In Channel Average Flow ²			57	58	

Pump Station Month-to-Date Average Flow 38 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.36 ft	(Last Collected: 7/15/2015)
Lower Twin Lake Gage Read	2.1 ft	
Goose Lake Gage Read	2.5 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/22/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			60	64	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			51	58	15
Locust Ditch Return (augmentation)	8	4			
Georges Ditch Return (augmentation)	2	8			
Reinhackle Springs			62	66	15
Alabama Gates Return (augmentation)	0	1			
At Pumpback Station ¹			48	44	15
Pump Station			45	41	
Langemann Gate to Delta			3	3	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			55	58	

Pump Station Month-to-Date Average Flow 38 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.36 ft	(Last Collected: 7/15/2015)
Lower Twin Lake Gage Read	2.1 ft	
Goose Lake Gage Read	2.5 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/23/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			59	63	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			52	57	15
Locust Ditch Return (augmentation)	9	4			
Georges Ditch Return (augmentation)	0	7			
Reinhackle Springs			56	66	15
Alabama Gates Return (augmentation)	0	1			
At Pumpback Station ¹			50	44	15
Pump Station			45	41	
Langemann Gate to Delta			4	3	
Weir to Delta			1	0	
LORP In Channel Average Flow ²			54	58	

Pump Station Month-to-Date Average Flow 39 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.36 ft	(Last Collected: 7/15/2015)
Lower Twin Lake Gage Read	2.1 ft	
Goose Lake Gage Read	2.5 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/24/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			59	62	15
Blackrock Ditch Return (augmentation)	0	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			52	57	15
Locust Ditch Return (augmentation)	9	5			
Georges Ditch Return (augmentation)	4	6			
Reinhackle Springs			55	65	15
Alabama Gates Return (augmentation)	0	1			
At Pumpback Station ¹			54	45	15
Pump Station			45	41	
Langemann Gate to Delta			7	3	
Weir to Delta			2	0	
LORP In Channel Average Flow ²			55	57	

Pump Station Month-to-Date Average Flow 39 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.36 ft	(Last Collected: 7/15/2015)
Lower Twin Lake Gage Read	2.1 ft	
Goose Lake Gage Read	2.5 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/25/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			58	61	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1.1	1			
Mazourka Canyon Road			51	56	15
Locust Ditch Return (augmentation)	9	5			
Georges Ditch Return (augmentation)	5	6			
Reinhackle Springs			58	65	15
Alabama Gates Return (augmentation)	0	1			
At Pumpback Station ¹			55	45	15
Pump Station			45	41	
Langemann Gate to Delta			8	4	
Weir to Delta			2	0	
LORP In Channel Average Flow ²			56	57	

Pump Station Month-to-Date Average Flow 39 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.36 ft	(Last Collected: 7/15/2015)
Lower Twin Lake Gage Read	2.1 ft	
Goose Lake Gage Read	2.5 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/26/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			58	61	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			50	55	15
Locust Ditch Return (augmentation)	9	6			
Georges Ditch Return (augmentation)	4	6			
Reinhackle Springs			58	65	15
Alabama Gates Return (augmentation)	0	1			
At Pumpback Station ¹			54	46	15
Pump Station			45	42	
Langemann Gate to Delta			8	4	
Weir to Delta			1	1	
LORP In Channel Average Flow ²			55	57	

Pump Station Month-to-Date Average Flow 39 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.36 ft	(Last Collected: 7/15/2015)
Lower Twin Lake Gage Read	2.1 ft	
Goose Lake Gage Read	2.5 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/27/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			59	60	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	0.9	1			
Mazourka Canyon Road			49	54	15
Locust Ditch Return (augmentation)	9	7			
Georges Ditch Return (augmentation)	4	6			
Reinhackle Springs			58	64	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			52	47	15
Pump Station			44	42	
Langemann Gate to Delta			8	4	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			55	56	

Pump Station Month-to-Date Average Flow 40 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.36 ft	(Last Collected: 7/15/2015)
Lower Twin Lake Gage Read	2.1 ft	
Goose Lake Gage Read	2.5 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/28/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			58	59	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	0.8	1			
Mazourka Canyon Road			49	53	15
Locust Ditch Return (augmentation)	9	7			
Georges Ditch Return (augmentation)	2	6			
Reinhackle Springs			58	64	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			45	47	15
Pump Station			37	42	
Langemann Gate to Delta			8	5	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			53	56	

Pump Station Month-to-Date Average Flow 40 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.36 ft	(Last Collected: 7/15/2015)
Lower Twin Lake Gage Read	2.1 ft	
Goose Lake Gage Read	2.5 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/29/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			60	59	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	0.8	1			
Mazourka Canyon Road			48	52	15
Locust Ditch Return (augmentation)	9	8			
Georges Ditch Return (augmentation)	1	6			
Reinhackle Springs			55	63	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			43	47	15
Pump Station			35	41	
Langemann Gate to Delta			8	5	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			52	55	

Pump Station Month-to-Date Average Flow 39 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.32 ft	(Last Collected: 7/29/2015)
Lower Twin Lake Gage Read	2.14 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/30/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			61	59	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			49	52	15
Locust Ditch Return (augmentation)	10	8			
Georges Ditch Return (augmentation)	0	5			
Reinhackle Springs			53	62	15
Alabama Gates Return (augmentation)	0	0			
At Pumpback Station ¹			43	47	15
Pump Station			35	41	
Langemann Gate to Delta			8	5	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			52	55	

Pump Station Month-to-Date Average Flow 39 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.32 ft	(Last Collected: 7/29/2015)
Lower Twin Lake Gage Read	2.14 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

Lower Owens River Project Flow Report for 07/31/2015

LORP Measuring Station	Augmenting Flows		Owens River Flows		
	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	Daily Avg Flow(cfs)	15 Day Avg Flow(cfs)	# Days of last 15 at 40+ cfs
Below River Intake			61	59	15
Blackrock Ditch Return (augmentation)	1	1			
Goose Lake Return (return flow)	1	1			
Billy Lake Return (augmentation)	1	1			
Mazourka Canyon Road			49	51	15
Locust Ditch Return (augmentation)	10	9			
Georges Ditch Return (augmentation)	0	4			
Reinhackle Springs			54	61	15
Alabama Gates Return (augmentation)	8	1			
At Pumpback Station ¹			43	47	15
Pump Station			35	41	
Langemann Gate to Delta			8	6	
Weir to Delta			0	0	
LORP In Channel Average Flow ²			52	55	

Pump Station Month-to-Date Average Flow 39 cfs

Blackrock Waterfowl Habitat Area

Flooded Unit	Area	Last Collected	Flow Rate	Flow Set Date
Thibaut ³	28 Acres	03/09/2015	0 cfs	04/01/2015
Winterton	86 Acres	05/06/2015	6 cfs	06/01/2015
Drew	235 Acres	05/06/2015	0 cfs	04/01/2015
Waggoner ³	0 Acres	05/31/2011	0 cfs	04/15/2011
Total Flooded Area	349 Acres			

Off-River Lakes and Ponds

Upper Twin Lake Gage Read	2.32 ft	(Last Collected: 7/29/2015)
Lower Twin Lake Gage Read	2.14 ft	
Goose Lake Gage Read	2.51 ft	
Thibaut Pond Flooded Area	28 Acres	(Last Collected: 03/09/2015)

1. Above Pump Station not constructed, the flow is the sum of the Pump station discharge, the Langemann Gate releases to the delta, and flow over the spillway weir to the delta.
 2. Average of the LORP Intake, Mazourka Canyon, Reinhackle Springs, and At Pumpback Station stations.
 3. Thibaut and Waggoner Water Areas are currently off.
- Note - All Data shown in this report is from field electronic measuring and data collection devices.
 Note - Data contained herein is preliminary and subject to change. Refer to the disclaimer:
<http://wsoweb.ladwp.com/Aqueduct/realtime/disclaimer.htm>

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Larry Benbrook

DATE: Wednesday, July 1st, 2015

REQUESTED BY: E. Tillemans x30256

FLOW CHANGE LOCATION **LORP Intake**

START DATE: July 1st, 2015 TIME: 8 AM

CHANGE FLOW FROM: 60 cfs TO 75 cfs at LORP Intake

To maintain required flows to the LORP, monitor and make adjustments to the Aqueduct Intake gates for at least one day following this flow change.

C: James Yannotta
Greg Loveland
Charlotte Rodrigues
Steve Butler
Ben Butler

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Larry Benbrook

DATE: July 1st,2015

REQUESTED BY: Ben Butler x30267

FLOW CHANGE LOCATION **Georges Ditch Return**

START DATE: July 2nd, 2015

TIME: ANY TIME

CHANGE FLOW FROM: 1 cfs TO 8 cfs At Georges Ditch Return to the LORP

C: James Yannotta
Greg Loveland
Ben Butler
Eric Tillemans
Robert Turner
Ben Arcularius
Jason Olin
Bruce Peterson

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Larry Benbrook

DATE: July 6th, 2015

REQUESTED BY: E. Tillemans x30256

FLOW CHANGE LOCATION **Alabama Gates**

START DATE: July 6th, 2015 TIME: 8 AM

CHANGE FLOW FROM: 15 cfs TO 0 cfs at Alabama Gates

C: James Yannotta
Clarence Martin
Charlotte Rodrigues
Steve Butler
Ben Butler

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Larry Benbrook

DATE: Tuesday, July 7th, 2015

REQUESTED BY: E. Tillemans x30256

FLOW CHANGE LOCATION **LORP Intake**

START DATE: July 7th, 2015 TIME: 8 AM

CHANGE FLOW FROM: 75 cfs TO 70 cfs at LORP Intake

To maintain required flows to the LORP, monitor and make adjustments to the Aqueduct Intake gates for at least one day following this flow change.

C: James Yannotta
Greg Loveland
Charlotte Rodrigues
Steve Butler
Ben Butler

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Larry Benbrook

DATE: July 9th, 2015

REQUESTED BY: E. Tillemans x30256

FLOW CHANGE LOCATION **Georges Ditch Return**

START DATE: July 9th, 2015 TIME: Any time

CHANGE FLOW FROM: 10 cfs TO 5 cfs At Georges Ditch Return

C: James Yannotta
Ben Butler
Robert Turner
Todd Bunn
Jason Olin
Bruce Peterson

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Larry Benbrook

DATE: Tuesday, July 14th, 2015

REQUESTED BY: E. Tillemans x30256

FLOW CHANGE LOCATION **LORP Intake**

START DATE: July 14th, 2015 TIME: 9 AM

CHANGE FLOW FROM: 70 cfs TO 60 cfs at LORP Intake

To maintain required flows to the LORP, monitor and make adjustments to the Aqueduct Intake gates for at least one day following this flow change.

C: James Yannotta
Greg Loveland
Charlotte Rodrigues
Steve Butler
Ben Butler

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Larry Benbrook

DATE: July 14th, 2015

REQUESTED BY: E. Tillemans x30256

FLOW CHANGE LOCATION **Georges Ditch Return**

START DATE: July 14th, 2015 TIME: Any time

CHANGE FLOW FROM: 5 cfs TO 10 cfs At Georges Ditch Return

C: James Yannotta
Ben Butler
Robert Turner
Todd Bunn
Jason Olin
Bruce Peterson

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Larry Benbrook

DATE: July 14th, 2015

REQUESTED BY: E. Tillemans x30256

FLOW CHANGE LOCATION **Locust Ditch Return**

START DATE: July 15th, 2015 TIME: 7 AM

CHANGE FLOW FROM: 0 cfs TO 5 cfs At Locust Ditch Return

C: James Yannotta
Ben Butler
Robert Turner
Todd Bunn
Jason Olin
Bruce Peterson

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Larry Benbrook

DATE: July 20th, 2015

REQUESTED BY: E. Tillemans x30256

FLOW CHANGE LOCATION **Georges Ditch Return**

START DATE: July 20th, 2015 TIME: Any time

CHANGE FLOW FROM: 10 cfs TO 5 cfs At Georges Ditch Return

C: James Yannotta
Ben Butler
Robert Turner
Todd Bunn
Jason Olin
Bruce Peterson

FLOW CHANGE REQUEST/NOTIFICATION

ATTN: Larry Benbrook

DATE: July 20th, 2015

REQUESTED BY: E. Tillemans x30256

FLOW CHANGE LOCATION **Locust Ditch Return**

START DATE: July 20th, 2015 TIME: Any time

CHANGE FLOW FROM: 5 cfs TO 10 cfs At Locust Ditch Return

C: James Yannotta
Ben Butler
Robert Turner
Todd Bunn
Jason Olin
Bruce Peterson

Quality Assurance and Calibration Procedures

The Los Angeles Department of Water and Power has a set standard to assure quality of all hydrological data collected. Procedures used to QA data vary based on the type of data collected and the device used to measure flow.

Data collected from sites utilizing area velocity flow meters are electronically monitored continuously. Sites are physically visited most days of the week to assure debris or vandalism hasn't affected the reading. Errors in the data collected may arise from several sources:

1. The transducers which detect the stage height and velocities have a tendency to drift.
2. Power outages occur occasionally thereby preventing the recording of data to the data loggers.
3. Occasionally the data loggers themselves malfunction.
4. Data can be lost or corrupted when it is transferred from the data loggers to the laptop.

Errors in discharge can originate from the instability of the relationship between velocity and stage height. This relationship varies temporally. It is affected by changes in the streambed that results from the flow of water over the bed, such as scour and fill, aquatic growth, ice, debris, or bed roughness.

To compensate for changes in the constantly shifting conditions multiple current meter measurements at each location per USGS standards are conducted per month. The current meter shots are taken at 2 foot intervals horizontally across the lined sections or 1 foot intervals at the sites where the measurements are taken in culverts. In each vertical section two separate measurements are taken (0.2 and 0.8) of the depth to achieve the best velocity average in the vertical. These vertical discharges are then added together to obtain a total flow in the section. The current meter data is logged in an on-board computer tracking the measurements as taken. That data is then extracted from the on-board computer to a PC using the FlowPack software that allows analysis of the data for erroneous measurements and is then converted to an Excel spreadsheet for ease of storage and printing. See Examples 1 – 3 for printout of software used to validate the current meter data.

Current meter data is used to develop velocity index tables. The tables require a minimum of 6 meter shots. After a table has been developed it is then downloaded into the on-site SonTek software which takes into account any variables within the meter section and applies any shifts to the discharge.

Data is collected and logged every 10 minutes utilizing SonTek area velocity flow meters. The data is downloaded from the meters once per month utilizing software provided by SonTek. The software "ViewArgonaut" gives us the ability to check items relevant to the performance of the meter. Battery voltage, beam strength, noise ratios, depth, and cell distance. (See Example 4) The software provides a trend of the data collected and displays it for quick comparisons, flagging discrepancies, one day at a time. Utilizing the ViewArgonaut software monthly reports are generated and the data is

reviewed. Using the current meter data collected during the month shifts are applied to the discharge to assure accuracy.

Augmentation Flows

Flows at several of the augmentation points are measured using weirs and flumes at sites that were pre-existing. Billy Lake has a one foot Parshall flume, Locust and Georges Returns have three foot weirs installed. All have stilling wells with dataloggers installed. The water surface elevation in the stillwell is measured each time the site is visited and verified it matches the staff gage for correct water depth through the measuring device. The still wells are flushed once every two months to assure the communication line is open and free of debris. The gage height data is logged on a module every 15 minutes. The modules are changed and processed every two weeks. Software used to process the data gives an hourly average gage and converts it to flow. It also gives the maximum and minimum flows for each day and time stamps it. The data is reviewed for any discrepancies which can be caused as a result of debris plugging the measuring device, a plugged stillwell, low batteries, etc.

SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:

- [Open a FlowTracker file](#)
- [Open many FlowTracker files/folders](#)

The current export settings are:

- Show Discharge Summary Report
- Export ASCII Discharge file (DIS)
- Export ASCII Control file (CTL)
- Export ASCII Summary file (SUM)
- Export ASCII Data file (DAT)
- Export FlowPack file (FPX)
- Put Headers on ASCII files

[Connect to a FlowTracker](#)

To download data and run diagnostics

070706.ORABR.LOR.WAD

Discharge Measurement Summary

Date Generated: Thu Sep 27 2007

File Information		Site Details	
File Name	070706.ORABR.LOR.WAD	Site Name	ORABR
Start Date and Time	2007/07/06 07:48:17	Operator(s)	DJT

System Information		Units	(English Units)
Sensor Type	FlowTracker	Distance	ft
Serial #	P1685	Velocity	ft/s
CPU Firmware Version	3.2	Area	ft^2
Software Ver	2.11	Discharge	cfs

Discharge Uncertainty		
Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.1%	0.5%
Velocity	0.3%	1.4%
Width	0.1%	0.1%
Method	0.8%	-
# Stations	1.6%	-
Overall	2.1%	1.8%

Summary			
Averaging Int.	40	# Stations	32
Start Edge	REW	Total Width	48.100
Mean SNR	18.7 dB	Total Area	69.016
Mean Temp	73.68 °F	Mean Depth	1.435
Disch. Equation	Mid-Section	Mean Velocity	0.6419
		Total Discharge	44.3025

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	07:48	23.60	None	0.000	0.0	0.0	0.0000	1.00	0.0000	0.000	0.0000	0.0
1	07:48	24.60	0.6	0.360	0.6	0.144	0.2762	1.00	0.2762	0.360	0.0994	0.2
2	07:50	25.60	0.6	0.640	0.6	0.256	0.5102	1.00	0.5102	0.640	0.3266	0.7
3	07:51	26.60	0.6	0.880	0.6	0.352	0.5938	1.00	0.5938	0.880	0.5225	1.2
4	07:52	27.60	0.6	1.180	0.6	0.472	0.6257	1.00	0.6257	1.180	0.7383	1.7
5	07:54	28.60	0.6	1.390	0.6	0.556	0.6302	1.00	0.6302	1.390	0.8761	2.0
6	07:55	29.60	0.2/0.8	1.520	0.2	1.216	0.8130	1.00	0.7078	1.520	1.0759	2.4
6	07:56	29.60	0.2/0.8	1.520	0.8	0.304	0.6027					
7	07:58	30.60	0.8/0.2	1.690	0.2	1.352	0.8468	1.00	0.7664	1.690	1.2952	2.9
7	07:57	30.60	0.8/0.2	1.690	0.8	0.338	0.6860					
8	07:59	31.60	0.2/0.8	1.700	0.2	1.360	0.8146	1.00	0.7037	2.040	1.4357	3.2
8	08:00	31.60	0.2/0.8	1.700	0.8	0.340	0.5928					
9	08:03	33.00	0.8/0.2	1.680	0.2	1.344	0.8383	1.00	0.7408	2.016	1.4935	3.4
9	08:01	33.00	0.8/0.2	1.680	0.8	0.336	0.6434					
10	08:05	34.00	0.2/0.8	1.600	0.2	1.280	0.8724	1.00	0.7398	2.400	1.7757	4.0
10	08:06	34.00	0.2/0.8	1.600	0.8	0.320	0.6073					
11	08:08	36.00	0.8/0.2	1.520	0.2	1.216	0.8186	1.00	0.6995	3.040	2.1264	4.8
11	08:07	36.00	0.8/0.2	1.520	0.8	0.304	0.5804					
12	08:09	38.00	0.2/0.8	1.500	0.2	1.200	0.8957	1.00	0.7461	3.000	2.2382	5.1
12	08:11	38.00	0.2/0.8	1.500	0.8	0.300	0.5965					
13	08:12	40.00	0.2/0.8	1.490	0.2	1.192	0.8245	1.00	0.6321	2.980	1.8837	4.3
13	08:13	40.00	0.2/0.8	1.490	0.8	0.298	0.4396					
14	08:15	42.00	0.2/0.8	1.510	0.2	1.208	0.8514	1.00	0.7548	3.020	2.2791	5.1
14	08:16	42.00	0.2/0.8	1.510	0.8	0.302	0.6581					
15	08:18	44.00	0.8/0.2	1.600	0.2	1.280	0.8278	1.00	0.7026	3.200	2.2484	5.1
15	08:17	44.00	0.8/0.2	1.600	0.8	0.320	0.5774					
16	08:19	46.00	0.2/0.8	1.620	0.2	1.296	0.8018	1.00	0.6916	3.240	2.2409	5.1
16	08:20	46.00	0.2/0.8	1.620	0.8	0.324	0.5814					
17	08:22	48.00	0.8/0.2	1.700	0.2	1.360	0.8396	1.00	0.7756	3.400	2.6372	6.0
17	08:21	48.00	0.8/0.2	1.700	0.8	0.340	0.7116					
18	08:23	50.00	0.2/0.8	1.800	0.2	1.440	0.9016	1.00	0.8251	3.600	2.9703	6.7
18	08:24	50.00	0.2/0.8	1.800	0.8	0.360	0.7487					
19	08:26	52.00	0.8/0.2	1.680	0.2	1.344	0.8271	1.00	0.7269	3.360	2.4425	5.5
19	08:25	52.00	0.8/0.2	1.680	0.8	0.336	0.6266					
20	08:27	54.00	0.2/0.8	1.780	0.2	1.424	0.7795	1.00	0.6763	3.560	2.4076	5.4
20	08:28	54.00	0.2/0.8	1.780	0.8	0.356	0.5732					
21	08:30	56.00	0.8/0.2	1.820	0.2	1.456	0.7329	1.00	0.6097	3.640	2.2193	5.0
21	08:29	56.00	0.8/0.2	1.820	0.8	0.364	0.4865					
22	08:32	58.00	0.2/0.8	1.820	0.2	1.456	0.7123	1.00	0.5540	3.640	2.0163	4.6
22	08:34	58.00	0.2/0.8	1.820	0.8	0.364	0.3957					
23	08:36	60.00	0.8/0.2	1.800	0.2	1.440	0.6949	1.00	0.6017	3.600	2.1660	4.9
23	08:35	60.00	0.8/0.2	1.800	0.8	0.360	0.5085					

- [Program Settings](#)
- [Quality Control Settings](#)
- [Show User's Manual](#)
- [Show Technical Manual](#)
- [Show Quick Start](#)
- [About FlowTracker](#)

English




A YSI Environmental Company

SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:




-  [Open a FlowTracker file](#)
-  [Open many FlowTracker files/folders](#)

The current export settings are:

- Show Discharge Summary Report
- Export ASCII Discharge file (DIS)
- Export ASCII Control file (CTL)
- Export ASCII Summary file (SUM)
- Export ASCII Data file (DAT)
- Export FlowPack file (FPX)
- Put Headers on ASCII files

-  [Connect to a FlowTracker](#)
To download data and run diagnostics

070706.0RABR.LOR.WAD








Quality Control

St	Loc	%Dep	Message
13	40.00	0.8	High standard error: 0.024

Automatic Quality Control Test (BeamCheck)



-  [Program Settings](#)
- [Quality Control Settings](#)
-  [Show User's Manual](#)
-  [Show Technical Manual](#)
-  [Show Quick Start](#)
-  [About FlowTracker](#)

 English
 

 A YSI Environmental Company

SonTek's FlowTracker

All the tools you need to work with the FlowTracker.

Select one of these actions:

-  [Open a FlowTracker file](#)
-  [Open many FlowTracker files/folders](#)

The current export settings are:

- Show Discharge Summary Report
- Export ASCII Discharge file (DIS)
- Export ASCII Control file (CTL)
- Export ASCII Summary file (SUM)
- Export ASCII Data file (DAT)
- Export FlowPack file (FPX)
- Put Headers on ASCII files

 [Connect to a FlowTracker](#)




To download data and run diagnostics

-  [Program Settings](#)
- [Quality Control Settings](#)
-  [Show User's Manual](#)
-  [Show Technical Manual](#)
-  [Show Quick Start](#)
-  [About FlowTracker](#)


 English



070706.0RABR.LOR.WAD



Quality Control			
St	Loc	%Dep	Message
13	40.00	0.8	High standard error: 0.024



FileName: BROR_070801_a.arg (Argonaut- SW 3000 kHz)



System	Argonaut-SW
Frequency	3000 kHz

File	BROR_070801_a
File Size	65.18 kB

Sample No	1
Sample Date	02/07/2007
Sample Time	13:28:38
Time Interval	180

Velocity Data:	
V1/X/E(cm/s)	27.8
V2/Y/N(cm/s)	2.4
V3/Z/U(cm/s)	--
Speed (cm/s)	27.9
Direction(deg)	85.1

Discharge Summary:	
V Beam (m)	0.426
Stage (m)	1.304 V
VMean (cm/s)	22.7
Flow (cfs)	50.21
Area (m2)	6.26
Vol (acre-ft)	0.7

Diagnostic Data:	
SNR1 (dB)	61
SNR2 (dB)	61
SNR3 (dB)	--
StErr1 (cm/s)	0.9
StErr2 (cm/s)	0.8
StErr3 (cm/s)	--
Mean StDev	0.9
Battery (V)	12.4

Discharge Measurement Summary

Date Generated: Wed Jul 15 2015

File Information

File Name 150702BR.RTN.WAD
Start Date and Time 2015/07/02 09:45:10

Site Details

Site Name BLACKROCK RTN
Operator(s) MKH

System Information

Sensor Type FlowTracker
Serial # P2352
CPU Firmware Version 3.7
Software Ver 2.30
Mounting Correction 0.0%

Units (English Units)

Distance ft
Velocity ft/s
Area ft²
Discharge cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.2%	0.0%
Velocity	0.6%	3.8%
Width	0.2%	0.2%
Method	2.8%	-
# Stations	5.8%	-
Overall	6.5%	3.9%

Summary

Averaging Int.	40	# Stations	9
Start Edge	LEW	Total Width	5.940
Mean SNR	18.5 dB	Total Area	6.117
Mean Temp	73.57 °F	Mean Depth	1.030
Disch. Equation	Mid-Section	Mean Velocity	0.1115
		Total Discharge	0.6822

Supplemental Data (Gauge Height Change = 0.000ft)

#	Time	Location	Gauge Height	Rated Flow	Comments
1	Thu Jul 2 09:44:38 PDT 2015	0.000	1.030		
2	Thu Jul 2 09:52:15 PDT 2015	5.940	1.030		

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	09:45	0.00	None	1.030	0.0	0.0	0.0000	1.00	0.0896	0.257	0.0231	3.4
1	09:45	0.50	0.6	1.030	0.6	0.412	0.0896	1.00	0.0896	0.515	0.0461	6.8
2	09:46	1.00	0.6	1.030	0.6	0.412	0.1224	1.00	0.1224	0.772	0.0945	13.9
3	09:46	2.00	0.6	1.030	0.6	0.412	0.1112	1.00	0.1112	1.030	0.1145	16.8
4	09:47	3.00	0.6	1.030	0.6	0.412	0.1237	1.00	0.1237	1.030	0.1274	18.7
5	09:49	4.00	0.6	1.030	0.6	0.412	0.1273	1.00	0.1273	1.030	0.1311	19.2
6	09:49	5.00	0.6	1.030	0.6	0.412	0.1089	1.00	0.1089	0.772	0.0841	12.3
7	09:50	5.50	0.6	1.030	0.6	0.412	0.0863	1.00	0.0863	0.484	0.0418	6.1
8	09:50	5.94	None	1.030	0.0	0.0	0.0000	1.00	0.0863	0.227	0.0195	2.9

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary




Date Generated: Wed Jul 15 2015

File Information

File Name 150702BR.RTN.WAD
 Start Date and Time 2015/07/02 09:45:10

Site Details

Site Name BLACKROCK RTN
 Operator(s) MKH



Discharge Measurement Summary

Date Generated: Wed Jul 15 2015

File Information

File Name 150702BR.RTN.WAD
Start Date and Time 2015/07/02 09:45:10

Site Details

Site Name BLACKROCK RTN
Operator(s) MKH

Quality Control

St	Loc	%Dep	Message
1	0.50	0.6	Boundary QC is Fair; possible boundary interference

Discharge Measurement Summary

Date Generated: Wed Jul 15 2015

File Information

File Name 150708BR.RTN.WAD
Start Date and Time 2015/07/08 13:18:47

Site Details

Site Name BLACKROCK RTN
Operator(s) MKH

System Information

Sensor Type FlowTracker
Serial # P2352
CPU Firmware Version 3.7
Software Ver 2.30
Mounting Correction 0.0%

Units (English Units)

Distance ft
Velocity ft/s
Area ft²
Discharge cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.2%	0.0%
Velocity	0.5%	2.3%
Width	0.2%	0.2%
Method	2.8%	-
# Stations	5.8%	-
Overall	6.5%	2.5%

Summary

Averaging Int.	40	# Stations	9
Start Edge	LEW	Total Width	5.940
Mean SNR	24.2 dB	Total Area	6.831
Mean Temp	74.17 °F	Mean Depth	1.150
Disch. Equation	Mid-Section	Mean Velocity	0.2164
		Total Discharge	1.4778

Supplemental Data (Gauge Height Change = 0.000ft)

#	Time	Location	Gauge Height	Rated Flow	Comments
1	Wed Jul 8 13:18:02 PDT 2015	0.000	1.150		
2	Wed Jul 8 13:27:26 PDT 2015	5.940	1.150		

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	13:18	0.00	None	1.150	0.0	0.0	0.0000	1.00	0.1932	0.287	0.0556	3.8
1	13:18	0.50	0.6	1.150	0.6	0.460	0.1932	1.00	0.1932	0.575	0.1111	7.5
2	13:19	1.00	0.6	1.150	0.6	0.460	0.2215	1.00	0.2215	0.862	0.1910	12.9
3	13:20	2.00	0.6	1.150	0.6	0.460	0.2310	1.00	0.2310	1.150	0.2656	18.0
4	13:23	3.00	0.6	1.150	0.6	0.460	0.2254	1.00	0.2254	1.150	0.2592	17.5
5	13:24	4.00	0.6	1.150	0.6	0.460	0.2159	1.00	0.2159	1.150	0.2482	16.8
6	13:25	5.00	0.6	1.150	0.6	0.460	0.2287	1.00	0.2287	0.862	0.1972	13.3
7	13:26	5.50	0.6	1.150	0.6	0.460	0.1890	1.00	0.1890	0.540	0.1021	6.9
8	13:26	5.94	None	1.150	0.0	0.0	0.0000	1.00	0.1890	0.253	0.0478	3.2

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary




Date Generated: Wed Jul 15 2015

File Information

File Name 150708BR.RTN.WAD
Start Date and Time 2015/07/08 13:18:47

Site Details

Site Name BLACKROCK RTN
Operator(s) MKH



Discharge Measurement Summary

Date Generated: Wed Jul 15 2015

File Information

File Name 150708BR.RTN.WAD
Start Date and Time 2015/07/08 13:18:47

Site Details

Site Name BLACKROCK RTN
Operator(s) MKH

Quality Control

No Quality Control warnings

Discharge Measurement Summary

Date Generated: Wed Jul 15 2015

File Information

File Name 150715BR.RTN.WAD
Start Date and Time 2015/07/15 08:12:42

Site Details

Site Name BLACKROCK RTN
Operator(s) MKH

System Information

Sensor Type FlowTracker
Serial # P2352
CPU Firmware Version 3.7
Software Ver 2.30
Mounting Correction 0.0%

Units (English Units)

Distance ft
Velocity ft/s
Area ft²
Discharge cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.2%	0.0%
Velocity	1.1%	2.9%
Width	0.2%	0.2%
Method	2.8%	-
# Stations	5.8%	-
Overall	6.6%	3.0%

Summary

Averaging Int.	40	# Stations	9
Start Edge	LEW	Total Width	5.940
Mean SNR	13.5 dB	Total Area	6.178
Mean Temp	68.58 °F	Mean Depth	1.040
Disch. Equation	Mid-Section	Mean Velocity	0.1220
		Total Discharge	0.7538

Supplemental Data (Gauge Height Change = 0.000ft)

#	Time	Location	Gauge Height	Rated Flow	Comments
1	Wed Jul 15 08:09:49 PDT 2015	0.000	1.040		
2	Wed Jul 15 08:22:26 PDT 2015	5.940	1.040		

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	08:12	0.00	None	1.040	0.0	0.0	0.0000	1.00	0.1047	0.260	0.0272	3.6
1	08:12	0.50	0.6	1.040	0.6	0.416	0.1047	1.00	0.1047	0.520	0.0544	7.2
2	08:13	1.00	0.6	1.040	0.6	0.416	0.1191	1.00	0.1191	0.780	0.0929	12.3
3	08:15	2.00	0.6	1.040	0.6	0.416	0.1378	1.00	0.1378	1.040	0.1433	19.0
4	08:16	3.00	0.6	1.040	0.6	0.416	0.1247	1.00	0.1247	1.040	0.1297	17.2
5	08:18	4.00	0.6	1.040	0.6	0.416	0.1112	1.00	0.1112	1.040	0.1157	15.3
6	08:19	5.00	0.6	1.040	0.6	0.416	0.1316	1.00	0.1316	0.780	0.1026	13.6
7	08:21	5.50	0.6	1.040	0.6	0.416	0.1227	1.00	0.1227	0.489	0.0600	8.0
8	08:21	5.94	None	1.040	0.0	0.0	0.0000	1.00	0.1227	0.229	0.0281	3.7

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary




Date Generated: Wed Jul 15 2015

File Information

File Name 150715BR.RTN.WAD
Start Date and Time 2015/07/15 08:12:42

Site Details

Site Name BLACKROCK RTN
Operator(s) MKH



Discharge Measurement Summary

Date Generated: Wed Jul 15 2015

File Information

File Name 150715BR.RTN.WAD
Start Date and Time 2015/07/15 08:12:42

Site Details

Site Name BLACKROCK RTN
Operator(s) MKH

Quality Control

St	Loc	%Dep	Message
1	0.50	0.6	High SNR variation during measurement: 4.7,5.2
		0.6	Boundary QC is Poor; possible boundary interference
2	1.00	0.6	High SNR variation during measurement: 5.6,5.6
		0.6	Boundary QC is Good; possible boundary interference
4	3.00	0.6	High SNR variation during measurement: 5.6,5.6
6	5.00	0.6	Boundary QC is Good; possible boundary interference

Discharge Measurement Summary

Date Generated: Wed Aug 12 2015

File Information

File Name 150729BR.RTN.WAD
Start Date and Time 2015/07/29 09:35:56

Site Details

Site Name BLACKROCK RTN
Operator(s) MKH

System Information

Sensor Type FlowTracker
Serial # P2352
CPU Firmware Version 3.7
Software Ver 2.30
Mounting Correction 0.0%

Units (English Units)

Distance ft
Velocity ft/s
Area ft²
Discharge cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.2%	0.0%
Velocity	1.1%	2.5%
Width	0.2%	0.2%
Method	2.8%	-
# Stations	5.8%	-
Overall	6.6%	2.7%

Summary

Averaging Int.	40	# Stations	9
Start Edge	LEW	Total Width	5.940
Mean SNR	11.6 dB	Total Area	6.593
Mean Temp	69.28 °F	Mean Depth	1.110
Disch. Equation	Mid-Section	Mean Velocity	0.1834
		Total Discharge	1.2089

Supplemental Data (Gauge Height Change = 0.000ft)

#	Time	Location	Gauge Height	Rated Flow	Comments
1	Wed Jul 29 09:34:15 PDT 2015	0.000	1.110		
2	Wed Jul 29 09:43:50 PDT 2015	5.940	1.110		

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	09:35	0.00	None	1.110	0.0	0.0	0.0000	1.00	0.1512	0.277	0.0420	3.5
1	09:35	0.50	0.6	1.110	0.6	0.444	0.1512	1.00	0.1512	0.555	0.0839	6.9
2	09:36	1.00	0.6	1.110	0.6	0.444	0.1946	1.00	0.1946	0.832	0.1620	13.4
3	09:37	2.00	0.6	1.110	0.6	0.444	0.2024	1.00	0.2024	1.110	0.2247	18.6
4	09:39	3.00	0.6	1.110	0.6	0.444	0.1886	1.00	0.1886	1.110	0.2094	17.3
5	09:40	4.00	0.6	1.110	0.6	0.444	0.1841	1.00	0.1841	1.110	0.2043	16.9
6	09:41	5.00	0.6	1.110	0.6	0.444	0.1893	1.00	0.1893	0.832	0.1576	13.0
7	09:42	5.50	0.6	1.110	0.6	0.444	0.1634	1.00	0.1634	0.522	0.0852	7.1
8	09:42	5.94	None	1.110	0.0	0.0	0.0000	1.00	0.1634	0.244	0.0399	3.3

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary




Date Generated: Wed Aug 12 2015

File Information

File Name 150729BR.RTN.WAD
 Start Date and Time 2015/07/29 09:35:56

Site Details

Site Name BLACKROCK RTN
 Operator(s) MKH



Discharge Measurement Summary

Date Generated: Wed Aug 12 2015

File Information

File Name 150729BR.RTN.WAD
Start Date and Time 2015/07/29 09:35:56

Site Details

Site Name BLACKROCK RTN
Operator(s) MKH

Quality Control

St	Loc	%Dep	Message
1	0.50	0.6	High SNR variation during measurement: 9.0,9.5
		0.6	Boundary QC is Poor; possible boundary interference
3	2.00	0.6	Boundary QC is Good; possible boundary interference
5	4.00	0.6	High SNR variation during measurement: 5.6,5.6
		0.6	Boundary QC is Good; possible boundary interference

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	1	0	6	52	0.322	0.01	0.922	0.039	0.036	0	51.6	50.3	65.8	150	146	0	30	29
2015	7	1	0	16	52	0.23	-0.046	0.919	0.033	0.03	0	52	50.7	63.2	151	147	0	30	29
2015	7	1	0	26	52	0.21	-0.026	0.915	0.033	0.03	0	52	50.3	63.6	151	146	0	30	29
2015	7	1	0	36	52	0.21	0.043	0.912	0.039	0.036	0	50.7	49.9	65.4	149	145	0	31	29
2015	7	1	0	46	52	0.322	0.013	0.909	0.036	0.033	0	51.2	49.9	65.8	149	145	0	30	29
2015	7	1	0	56	52	0.21	-0.049	0.909	0.039	0.036	0	51.2	49	66.2	149	144	0	30	30
2015	7	1	1	6	52	0.171	-0.049	0.906	0.043	0.039	0	52	50.3	65.8	151	146	0	30	29
2015	7	1	1	16	52	0.2	-0.033	0.906	0.036	0.033	0	50.7	49	67.1	148	143	0	30	29
2015	7	1	1	26	52	0.243	-0.016	0.906	0.039	0.036	0	50.3	48.6	66.7	147	143	0	30	30
2015	7	1	1	36	52	0.262	-0.007	0.902	0.039	0.036	0	51.2	49.5	67.5	150	144	0	31	29
2015	7	1	1	46	52	0.194	0.026	0.902	0.036	0.033	0	51.6	50.3	67.1	150	146	0	30	29
2015	7	1	1	56	52	0.246	-0.046	0.902	0.036	0.033	0	52	49.9	64.5	151	145	0	30	29
2015	7	1	2	6	52	0.187	-0.02	0.899	0.033	0.03	0	52.5	50.3	67.1	152	146	0	30	29
2015	7	1	2	16	52	0.207	0.01	0.899	0.039	0.039	0	51.2	49.9	69.2	149	145	0	30	29
2015	7	1	2	26	52	0.18	-0.056	0.899	0.039	0.036	0	52.5	50.3	66.2	152	147	0	30	30
2015	7	1	2	36	52	0.243	0.003	0.899	0.033	0.03	0	51.6	49.9	68.4	150	145	0	30	29
2015	7	1	2	46	52	0.187	-0.056	0.896	0.039	0.036	0	50.7	49.5	69.2	149	144	0	31	29
2015	7	1	2	56	52	0.207	-0.049	0.896	0.049	0.049	0	52	50.3	67.5	152	147	0	31	30
2015	7	1	3	6	52	0.167	-0.016	0.896	0.036	0.033	0	51.2	49	69.2	150	144	0	31	30
2015	7	1	3	16	52	0.233	-0.056	0.896	0.039	0.036	0	53.3	51.6	67.5	154	150	0	30	30
2015	7	1	3	26	52	0.21	0.052	0.892	0.036	0.033	0	52	50.7	67.1	151	147	0	30	29
2015	7	1	3	36	52	0.223	0.082	0.892	0.033	0.03	0	52	50.7	67.5	151	147	0	30	29
2015	7	1	3	46	52	0.167	-0.036	0.892	0.039	0.036	0	51.2	49	69.7	149	144	0	30	30
2015	7	1	3	56	52	0.161	-0.02	0.892	0.039	0.039	0	50.3	49.5	68.4	147	144	0	30	29
2015	7	1	4	6	52	0.223	-0.02	0.889	0.039	0.039	0	50.3	49	70.1	147	143	0	30	29
2015	7	1	4	16	52	0.18	-0.007	0.889	0.036	0.033	0	49.5	47.7	70.1	146	141	0	31	30
2015	7	1	4	26	52	0.171	-0.095	0.886	0.046	0.043	0	48.6	47.7	69.7	144	140	0	31	29
2015	7	1	4	36	52	0.121	-0.066	0.886	0.043	0.039	0	49.9	47.3	69.7	146	140	0	30	30
2015	7	1	4	46	52	0.226	0.036	0.883	0.033	0.03	0	49	47.7	69.2	144	140	0	30	29
2015	7	1	4	56	52	0.197	-0.079	0.883	0.033	0.03	0	48.6	47.3	68.8	143	139	0	30	29
2015	7	1	5	6	52	0.184	0.013	0.879	0.039	0.036	0	48.6	47.3	69.2	144	139	0	31	29
2015	7	1	5	16	52	0.128	0	0.876	0.039	0.039	0	48.6	47.3	69.7	143	139	0	30	29
2015	7	1	5	26	52	0.19	-0.046	0.873	0.036	0.033	0	47.3	46.9	68.4	141	139	0	31	30
2015	7	1	5	36	52	0.085	-0.056	0.869	0.036	0.033	0	46.9	45.6	69.2	140	136	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	1	5	46	52	0.059	0.036	0.866	0.046	0.043	0	47.3	45.6	70.1	140	136	0	30	30
2015	7	1	5	56	52	0.161	-0.026	0.866	0.036	0.033	0	46.9	46.4	70.1	140	138	0	31	30
2015	7	1	6	6	52	0.22	0.013	0.86	0.033	0.03	0	52.5	50.3	61.9	152	147	0	30	30
2015	7	1	6	16	52	0.21	0.043	0.86	0.039	0.036	0	56.8	55	60.2	162	158	0	30	30
2015	7	1	6	26	52	0.148	0.072	0.856	0.039	0.036	0	62.4	60.6	49.5	175	170	0	30	29
2015	7	1	6	36	52	0.177	0.098	0.86	0.039	0.039	0	62.4	60.6	51.6	175	170	0	30	29
2015	7	1	6	46	52	0.174	0.151	0.86	0.039	0.036	0	61.9	60.2	53.3	175	170	0	31	30
2015	7	1	6	56	52	0.207	0.141	0.86	0.043	0.039	0	61.1	59.3	55.9	173	168	0	31	30
2015	7	1	7	6	52	0.223	0.108	0.856	0.039	0.036	0	60.6	58.5	57.6	171	166	0	30	30
2015	7	1	7	16	52	0.2	0.164	0.856	0.039	0.039	0	58.9	57.2	58.5	168	163	0	31	30
2015	7	1	7	26	52	0.164	0.177	0.856	0.039	0.036	0	58.9	56.8	60.2	167	162	0	30	30
2015	7	1	7	36	52	0.167	0.167	0.856	0.039	0.039	0	57.6	55.9	61.1	165	160	0	31	30
2015	7	1	7	46	52	0.184	0.059	0.853	0.043	0.039	0	56.8	55.5	61.9	163	159	0	31	30
2015	7	1	7	56	52	0.164	0.194	0.853	0.039	0.036	0	55.9	55	61.9	161	157	0	31	29
2015	7	1	8	6	52	0.144	0.125	0.853	0.036	0.033	0	55	53.8	63.6	158	155	0	30	30
2015	7	1	8	16	52	0.249	0.131	0.853	0.039	0.036	0	54.6	52.9	65.4	157	153	0	30	30
2015	7	1	8	26	52	0.217	0.177	0.85	0.033	0.03	0	54.2	52.9	65.4	157	152	0	31	29
2015	7	1	8	36	52	0.23	0.105	0.85	0.036	0.033	0	54.2	52.9	65.4	156	152	0	30	29
2015	7	1	8	46	52	0.174	0.207	0.85	0.036	0.033	0	53.8	51.6	65.4	155	151	0	30	31
2015	7	1	8	56	52	0.135	0.148	0.846	0.046	0.043	0	53.8	52	65.4	155	151	0	30	30
2015	7	1	9	6	52	0.148	0.18	0.846	0.036	0.033	0	53.3	51.6	63.6	155	150	0	31	30
2015	7	1	9	16	52	0.112	0.184	0.843	0.036	0.033	0	53.8	52.9	62.8	155	152	0	30	29
2015	7	1	9	26	52	0.164	0.203	0.843	0.036	0.033	0	53.8	52	62.8	155	151	0	30	30
2015	7	1	9	36	52	0.203	0.233	0.84	0.033	0.03	0	54.2	52.5	62.4	156	151	0	30	29
2015	7	1	9	46	52	0.22	0.19	0.84	0.039	0.036	0	54.6	52.5	61.5	157	152	0	30	30
2015	7	1	9	56	52	0.184	0.213	0.837	0.039	0.036	0	54.2	52.9	61.5	156	152	0	30	29
2015	7	1	10	6	52	0.141	0.174	0.83	0.036	0.033	0	54.2	53.3	60.6	157	153	0	31	29
2015	7	1	10	16	52	0.21	0.338	0.83	0.036	0.033	0	55	52.9	61.1	158	153	0	30	30
2015	7	1	10	26	52	0.135	0.223	0.827	0.039	0.036	0	54.2	52.5	61.1	157	152	0	31	30
2015	7	1	10	36	52	0.2	0.282	0.823	0.039	0.039	0	54.2	52.5	62.4	156	152	0	30	30
2015	7	1	10	46	52	0.243	0.217	0.823	0.046	0.043	0	54.6	52.5	61.5	157	152	0	30	30
2015	7	1	10	56	52	0.207	0.279	0.823	0.033	0.03	0	54.2	52.5	62.8	156	152	0	30	30
2015	7	1	11	6	52	0.167	0.23	0.82	0.039	0.036	0	54.6	52.5	61.1	157	152	0	30	30
2015	7	1	11	16	52	0.161	0.161	0.82	0.039	0.036	0	54.6	53.8	63.6	157	155	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	1	11	26	52	0.243	0.259	0.82	0.039	0.036	0	54.2	53.3	64.5	157	153	0	31	29
2015	7	1	11	36	52	0.187	0.226	0.82	0.039	0.039	0	55	53.3	64.1	158	154	0	30	30
2015	7	1	11	46	52	0.18	0.174	0.82	0.036	0.033	0	54.2	52.5	64.1	157	152	0	31	30
2015	7	1	11	56	52	0.167	0.164	0.82	0.039	0.039	0	54.2	52.9	64.5	157	153	0	31	30
2015	7	1	12	6	52	0.249	0.194	0.82	0.036	0.033	0	54.6	52.5	65.4	157	152	0	30	30
2015	7	1	12	16	52	0.24	0.144	0.817	0.036	0.033	0	53.8	52.5	66.7	155	152	0	30	30
2015	7	1	12	26	52	0.21	0.22	0.817	0.039	0.036	0	53.3	52.9	66.7	155	152	0	31	29
2015	7	1	12	36	52	0.151	0.203	0.817	0.039	0.036	0	52.9	51.2	67.1	154	149	0	31	30
2015	7	1	12	46	52	0.161	0.144	0.817	0.033	0.03	0	53.3	51.6	67.5	154	150	0	30	30
2015	7	1	12	56	52	0.203	0.167	0.817	0.039	0.036	0	52.9	52.5	67.1	154	151	0	31	29
2015	7	1	13	6	52	0.121	0.226	0.817	0.036	0.033	0	52.9	51.6	67.9	153	150	0	30	30
2015	7	1	13	16	52	0.23	0.102	0.817	0.039	0.036	0	52.5	51.2	68.4	152	148	0	30	29
2015	7	1	13	26	52	0.19	0.171	0.817	0.036	0.033	0	53.3	51.6	68.4	154	149	0	30	29
2015	7	1	13	36	52	0.194	0.167	0.817	0.039	0.039	0	52.5	50.7	69.2	153	147	0	31	29
2015	7	1	13	46	52	0.253	0.141	0.82	0.033	0.03	0	53.3	51.2	69.2	154	149	0	30	30
2015	7	1	13	56	52	0.203	0.112	0.817	0.036	0.033	0	52.5	51.2	70.1	152	148	0	30	29
2015	7	1	14	6	52	0.223	0.151	0.817	0.043	0.039	0	53.3	51.6	70.1	154	149	0	30	29
2015	7	1	14	16	52	0.131	0.072	0.82	0.036	0.033	0	52.9	50.3	70.5	153	146	0	30	29
2015	7	1	14	26	52	0.167	0.016	0.82	0.036	0.033	0	52.5	50.7	71.4	152	147	0	30	29
2015	7	1	14	36	52	0.148	0.108	0.817	0.036	0.033	0	52.9	51.2	71	153	148	0	30	29
2015	7	1	14	46	52	0.131	0.148	0.82	0.033	0.03	0	54.2	50.7	69.7	156	148	0	30	30
2015	7	1	14	56	52	0.194	0.115	0.82	0.039	0.039	0	52.9	51.2	70.1	153	148	0	30	29
2015	7	1	15	6	52	0.187	0.052	0.82	0.033	0.03	0	52	50.3	71	151	146	0	30	29
2015	7	1	15	16	52	0.174	0.102	0.82	0.036	0.033	0	53.8	49.9	69.7	154	146	0	29	30
2015	7	1	15	26	52	0.098	0.128	0.817	0.036	0.033	0	56.8	54.6	64.9	161	156	0	29	29
2015	7	1	15	36	52	0.157	0.197	0.82	0.039	0.039	0	56.3	53.8	64.9	161	154	0	30	29
2015	7	1	15	46	52	0.184	0.075	0.817	0.039	0.036	0	55	52.5	66.7	158	152	0	30	30
2015	7	1	15	56	52	0.207	0.098	0.82	0.036	0.033	0	54.6	52.5	67.5	156	152	0	29	30
2015	7	1	16	6	52	0.174	0.043	0.817	0.033	0.03	0	54.6	52.5	67.5	157	151	0	30	29
2015	7	1	16	16	52	0.197	0.039	0.817	0.036	0.033	0	54.2	51.6	68.4	155	149	0	29	29
2015	7	1	16	26	52	0.138	0.016	0.817	0.036	0.033	0	53.3	50.7	69.2	154	148	0	30	30
2015	7	1	16	36	52	0.098	0.089	0.82	0.039	0.039	0	53.3	51.6	68.8	154	149	0	30	29
2015	7	1	16	46	52	0.2	0.056	0.817	0.03	0.03	0	52.5	50.7	70.1	152	147	0	30	29
2015	7	1	16	56	52	0.141	0.046	0.82	0.046	0.043	0	52	49.9	70.1	151	145	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	1	17	6	52	0.184	0.033	0.82	0.039	0.036	0	51.6	49.9	70.5	150	145	0	30	29
2015	7	1	17	16	52	0.167	0.01	0.82	0.033	0.03	0	52.5	49.9	71.4	152	145	0	30	29
2015	7	1	17	26	52	0.23	0.059	0.82	0.039	0.036	0	51.6	49	70.1	150	144	0	30	30
2015	7	1	17	36	52	0.171	0.059	0.817	0.033	0.03	0	49.5	48.6	71.8	145	142	0	30	29
2015	7	1	17	46	52	0.177	-0.01	0.817	0.043	0.039	0	49.9	47.3	71.8	145	140	0	29	30
2015	7	1	17	56	52	0.125	0.016	0.817	0.036	0.033	0	48.2	47.3	72.2	142	139	0	30	29
2015	7	1	18	6	52	0.18	-0.056	0.817	0.036	0.033	0	48.2	47.7	72.7	142	140	0	30	29
2015	7	1	18	16	52	0.118	0.108	0.817	0.039	0.036	0	48.2	47.7	73.1	142	140	0	30	29
2015	7	1	18	26	52	0.092	0.01	0.817	0.039	0.036	0	48.2	47.3	72.2	142	139	0	30	29
2015	7	1	18	36	52	0.112	0.052	0.817	0.039	0.036	0	48.6	47.3	72.2	143	139	0	30	29
2015	7	1	18	46	52	0.171	0.039	0.817	0.039	0.036	0	48.6	46.9	72.2	143	138	0	30	29
2015	7	1	18	56	52	0.135	0	0.817	0.036	0.033	0	47.3	46.9	71.8	140	138	0	30	29
2015	7	1	19	6	52	0.203	0.013	0.817	0.039	0.036	0	47.3	46.4	72.2	140	137	0	30	29
2015	7	1	19	16	52	0.092	0.036	0.817	0.036	0.033	0	48.2	46.4	71.8	142	137	0	30	29
2015	7	1	19	26	52	0.138	0.003	0.817	0.039	0.039	0	49.5	47.7	71	145	141	0	30	30
2015	7	1	19	36	52	0.187	0.007	0.817	0.039	0.036	0	49.5	47.7	70.5	145	140	0	30	29
2015	7	1	19	46	52	0.151	-0.056	0.817	0.036	0.033	0	49.9	48.2	69.7	146	141	0	30	29
2015	7	1	19	56	52	0.121	-0.003	0.817	0.033	0.03	0	48.6	47.7	70.5	143	140	0	30	29
2015	7	1	20	6	52	0.039	0.039	0.817	0.036	0.033	0	49	47.3	71.4	144	139	0	30	29
2015	7	1	20	16	52	0.082	0.043	0.814	0.039	0.036	0	50.7	49	68.8	148	143	0	30	29
2015	7	1	20	26	52	0.118	0.039	0.814	0.043	0.039	0	51.6	50.7	67.5	150	147	0	30	29
2015	7	1	20	36	52	0.095	0.085	0.814	0.039	0.039	0	52	49.9	67.9	151	145	0	30	29
2015	7	1	20	46	52	0.118	0.069	0.814	0.033	0.03	0	52.9	51.2	67.5	153	148	0	30	29
2015	7	1	20	56	52	0.092	0.056	0.814	0.033	0.03	0	49.9	49.9	69.7	146	144	0	30	28
2015	7	1	21	6	52	0.092	0.01	0.814	0.036	0.033	0	50.7	49.5	68.8	148	144	0	30	29
2015	7	1	21	16	52	0.164	-0.013	0.814	0.036	0.033	0	49.9	49	69.7	146	143	0	30	29
2015	7	1	21	26	52	0.148	0	0.814	0.033	0.03	0	49	47.3	70.1	144	139	0	30	29
2015	7	1	21	36	52	0.062	-0.013	0.814	0.033	0.03	0	49	47.7	70.5	144	140	0	30	29
2015	7	1	21	46	52	0.18	0.016	0.814	0.039	0.039	0	48.6	48.2	70.5	143	141	0	30	29
2015	7	1	21	56	52	0.167	0.02	0.814	0.033	0.03	0	48.2	47.3	70.1	142	139	0	30	29
2015	7	1	22	6	52	0.141	-0.052	0.814	0.039	0.039	0	48.2	47.7	69.7	143	140	0	31	29
2015	7	1	22	16	52	0.148	0	0.814	0.036	0.033	0	49	47.3	70.1	144	139	0	30	29
2015	7	1	22	26	52	0.085	-0.023	0.81	0.033	0.03	0	48.2	46.9	70.5	143	138	0	31	29
2015	7	1	22	36	52	0.112	0.023	0.81	0.043	0.039	0	48.6	46.9	69.7	143	138	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	1	22	46	52	0.174	-0.03	0.81	0.036	0.033	0	48.6	46.9	69.7	143	138	0	30	29
2015	7	1	22	56	52	0.194	-0.079	0.81	0.033	0.03	0	48.2	46.9	70.1	142	138	0	30	29
2015	7	1	23	6	52	0.128	-0.026	0.81	0.043	0.039	0	47.3	46.4	70.1	140	137	0	30	29
2015	7	1	23	16	52	0.102	-0.02	0.81	0.039	0.036	0	47.7	46.9	70.1	142	138	0	31	29
2015	7	1	23	26	52	0.125	0.03	0.81	0.033	0.03	0	48.2	46.9	70.1	142	138	0	30	29
2015	7	1	23	36	52	0.115	-0.039	0.81	0.039	0.039	0	48.2	46.9	70.1	142	138	0	30	29
2015	7	1	23	46	52	0.092	-0.056	0.81	0.039	0.036	0	48.2	46.9	69.2	142	139	0	30	30
2015	7	1	23	56	52	0.072	0.033	0.807	0.033	0.03	0	48.6	46.9	68.8	143	139	0	30	30
2015	7	2	0	6	52	0.138	-0.043	0.807	0.033	0.03	0	53.8	51.6	64.5	155	150	0	30	30
2015	7	2	0	16	52	0.207	0.108	0.804	0.033	0.03	0	55.9	55	59.8	160	157	0	30	29
2015	7	2	0	26	52	0.118	0.062	0.804	0.039	0.039	0	56.8	55	60.6	162	157	0	30	29
2015	7	2	0	36	52	0.131	0.095	0.804	0.033	0.03	0	56.3	55	61.1	161	157	0	30	29
2015	7	2	0	46	52	0.18	0.079	0.801	0.039	0.036	0	55.5	54.6	61.1	160	156	0	31	29
2015	7	2	0	56	52	0.161	0.092	0.797	0.033	0.03	0	55.9	54.6	58.9	160	156	0	30	29
2015	7	2	1	6	52	0.075	0.108	0.801	0.033	0.03	0	55	53.8	61.9	158	154	0	30	29
2015	7	2	1	16	52	0.102	0.075	0.801	0.039	0.036	0	54.2	52.9	61.9	156	152	0	30	29
2015	7	2	1	26	52	0.194	0.016	0.801	0.036	0.033	0	53.3	51.6	63.2	154	150	0	30	30
2015	7	2	1	36	52	0.125	0.052	0.801	0.033	0.03	0	52	51.2	64.5	151	149	0	30	30
2015	7	2	1	46	52	0.157	0.112	0.797	0.036	0.033	0	53.3	52	63.2	154	150	0	30	29
2015	7	2	1	56	52	0.151	0.039	0.797	0.033	0.03	0	54.2	53.3	62.4	156	153	0	30	29
2015	7	2	2	6	52	0.115	0.154	0.804	0.033	0.03	0	54.2	52.5	63.6	156	151	0	30	29
2015	7	2	2	16	52	0.069	0.135	0.791	0.039	0.039	0	58.9	58	58.5	167	164	0	30	29
2015	7	2	2	26	52	0.121	0.21	0.804	0.039	0.039	0	58.5	56.8	58.9	166	161	0	30	29
2015	7	2	2	36	52	0.197	0.125	0.804	0.036	0.033	0	57.2	55.9	60.2	163	159	0	30	29
2015	7	2	2	46	52	0.197	0.072	0.801	0.039	0.036	0	57.2	55.5	58.5	164	159	0	31	30
2015	7	2	2	56	52	0.112	0.089	0.797	0.039	0.036	0	60.6	58.9	54.2	171	167	0	30	30
2015	7	2	3	6	52	0.131	0.056	0.801	0.039	0.036	0	60.6	58	56.3	170	164	0	29	29
2015	7	2	3	16	52	0.203	0.148	0.804	0.039	0.036	0	58.9	57.6	56.3	167	163	0	30	29
2015	7	2	3	26	52	0.112	0.112	0.801	0.033	0.03	0	60.2	58	53.8	170	164	0	30	29
2015	7	2	3	36	52	0.223	0.2	0.807	0.036	0.033	0	60.2	58.5	55.5	170	165	0	30	29
2015	7	2	3	46	52	0.144	0.131	0.807	0.039	0.039	0	58	56.3	57.6	165	160	0	30	29
2015	7	2	3	56	52	0.141	0.125	0.804	0.039	0.039	0	57.2	55.5	58	163	159	0	30	30
2015	7	2	4	6	52	0.125	0.125	0.807	0.036	0.033	0	56.8	55.5	56.3	163	159	0	31	30
2015	7	2	4	16	52	0.095	0.125	0.807	0.039	0.039	0	56.8	54.6	58	162	157	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	2	4	26	52	0.151	0.164	0.807	0.036	0.033	0	56.3	54.2	62.4	161	155	0	30	29
2015	7	2	4	36	52	0.174	0.164	0.807	0.039	0.039	0	55	53.3	63.6	158	153	0	30	29
2015	7	2	4	46	52	0.167	0.177	0.807	0.039	0.039	0	54.2	53.3	63.6	156	153	0	30	29
2015	7	2	4	56	52	0.148	0.177	0.807	0.039	0.039	0	53.8	52.5	64.5	156	151	0	31	29
2015	7	2	5	6	52	0.112	0.144	0.807	0.039	0.036	0	53.3	52	65.4	154	150	0	30	29
2015	7	2	5	16	52	0.128	0.125	0.807	0.033	0.03	0	52.5	51.6	64.9	153	149	0	31	29
2015	7	2	5	26	52	0.148	0.187	0.807	0.036	0.033	0	52.5	50.7	64.9	152	147	0	30	29
2015	7	2	5	36	52	0.079	0.102	0.807	0.033	0.03	0	52.5	50.3	65.8	152	147	0	30	30
2015	7	2	5	46	52	0.174	0.148	0.81	0.039	0.039	0	52	50.3	65.4	151	146	0	30	29
2015	7	2	5	56	52	0.174	0.22	0.81	0.039	0.036	0	51.2	49.5	66.2	150	145	0	31	30
2015	7	2	6	6	52	0.184	0.144	0.807	0.039	0.039	0	51.6	49.5	66.2	150	145	0	30	30
2015	7	2	6	16	52	0.259	0.213	0.807	0.039	0.036	0	51.6	49.9	66.2	150	146	0	30	30
2015	7	2	6	26	52	0.203	0.177	0.807	0.039	0.036	0	50.7	49.9	66.7	149	145	0	31	29
2015	7	2	6	36	52	0.213	0.151	0.807	0.036	0.033	0	51.2	49.9	65.8	150	145	0	31	29
2015	7	2	6	46	52	0.151	0.213	0.807	0.036	0.033	0	51.6	49.9	65.8	151	146	0	31	30
2015	7	2	6	56	52	0.154	0.243	0.807	0.039	0.036	0	52	50.3	66.2	151	146	0	30	29
2015	7	2	7	6	52	0.095	0.276	0.807	0.036	0.033	0	51.6	49.9	65.4	151	146	0	31	30
2015	7	2	7	16	52	0.128	0.217	0.807	0.039	0.036	0	51.6	49.9	65.4	150	146	0	30	30
2015	7	2	7	26	52	0.207	0.223	0.807	0.036	0.033	0	52	51.2	65.4	151	148	0	30	29
2015	7	2	7	36	52	0.115	0.154	0.807	0.039	0.036	0	52.5	51.2	64.5	153	149	0	31	30
2015	7	2	7	46	52	0.203	0.243	0.807	0.039	0.036	0	52.9	51.6	64.9	153	150	0	30	30
2015	7	2	7	56	52	0.105	0.184	0.804	0.036	0.033	0	52.9	51.6	64.5	153	149	0	30	29
2015	7	2	8	6	52	0.151	0.207	0.804	0.039	0.036	0	52.5	51.2	64.9	152	149	0	30	30
2015	7	2	8	16	52	0.187	0.197	0.804	0.033	0.03	0	52	51.2	64.9	151	148	0	30	29
2015	7	2	8	26	52	0.135	0.207	0.801	0.033	0.03	0	52	50.7	64.9	151	148	0	30	30
2015	7	2	8	36	52	0.148	0.112	0.801	0.039	0.036	0	52	50.7	64.5	152	148	0	31	30
2015	7	2	8	46	52	0.089	0.2	0.801	0.039	0.036	0	52.5	50.7	64.5	152	147	0	30	29
2015	7	2	8	56	52	0.184	0.144	0.797	0.036	0.033	0	52.5	51.6	65.4	152	149	0	30	29
2015	7	2	9	6	52	0.148	0.144	0.797	0.036	0.033	0	51.2	49.9	65.4	149	146	0	30	30
2015	7	2	9	16	52	0.167	0.131	0.794	0.033	0.03	0	50.7	49.9	66.2	148	146	0	30	30
2015	7	2	9	26	52	0.164	0.085	0.794	0.033	0.03	0	50.7	49.9	65.8	149	146	0	31	30
2015	7	2	9	36	52	0.174	0.118	0.791	0.036	0.033	0	50.3	49.5	66.7	148	145	0	31	30
2015	7	2	9	46	52	0.128	0.167	0.791	0.039	0.036	0	49.9	49	67.1	146	144	0	30	30
2015	7	2	9	56	52	0.128	0.092	0.791	0.033	0.03	0	51.2	50.3	65.8	149	146	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	2	10	6	52	0.2	0.128	0.791	0.036	0.033	0	51.2	50.3	67.1	150	147	0	31	30
2015	7	2	10	16	52	0.167	0.141	0.791	0.046	0.043	0	51.2	49.5	67.9	149	144	0	30	29
2015	7	2	10	26	52	0.151	0.02	0.794	0.039	0.039	0	50.7	49.5	67.1	148	144	0	30	29
2015	7	2	10	36	52	0.102	0.108	0.794	0.043	0.043	0	51.2	49.9	68.4	149	146	0	30	30
2015	7	2	10	46	52	0.128	0.092	0.794	0.033	0.03	0	52	50.3	67.5	151	147	0	30	30
2015	7	2	10	56	52	0.154	0.098	0.794	0.039	0.036	0	49.9	48.2	67.9	146	142	0	30	30
2015	7	2	11	6	52	0.121	-0.016	0.794	0.036	0.033	0	51.6	49.9	67.9	150	146	0	30	30
2015	7	2	11	16	52	0.171	0.02	0.797	0.039	0.036	0	50.7	51.2	67.5	149	148	0	31	29
2015	7	2	11	26	52	0.121	-0.01	0.797	0.033	0.03	0	51.2	49.9	67.1	149	145	0	30	29
2015	7	2	11	36	52	0.079	0.039	0.801	0.039	0.036	0	50.3	49	67.5	147	143	0	30	29
2015	7	2	11	46	52	0.072	0.026	0.801	0.039	0.036	0	50.3	48.6	68.4	147	142	0	30	29
2015	7	2	11	56	52	0.184	0.089	0.801	0.039	0.036	0	52	50.7	67.5	151	147	0	30	29
2015	7	2	12	6	52	0.161	0.056	0.804	0.039	0.036	0	52.5	51.2	67.1	152	149	0	30	30
2015	7	2	12	16	52	0.098	0.016	0.804	0.033	0.03	0	51.2	49.9	67.1	149	145	0	30	29
2015	7	2	12	26	52	0.105	-0.049	0.807	0.043	0.039	0	52.5	50.7	68.4	152	148	0	30	30
2015	7	2	12	36	52	0.18	0.016	0.807	0.033	0.03	0	53.3	52.5	67.5	154	151	0	30	29
2015	7	2	12	46	52	0.128	0.098	0.807	0.039	0.036	0	54.2	52.9	66.2	156	152	0	30	29
2015	7	2	12	56	52	0.151	0.095	0.807	0.033	0.03	0	55.5	54.2	63.6	159	155	0	30	29
2015	7	2	13	6	52	0.138	0.151	0.81	0.036	0.033	0	54.6	52.5	66.7	157	151	0	30	29
2015	7	2	13	16	52	0.089	0.115	0.81	0.033	0.03	0	55	53.3	66.7	158	153	0	30	29
2015	7	2	13	26	52	0.125	0.085	0.81	0.039	0.036	0	54.2	52.9	67.5	156	152	0	30	29
2015	7	2	13	36	52	0.171	0.072	0.81	0.039	0.036	0	53.8	52.5	68.4	155	151	0	30	29
2015	7	2	13	46	52	0.135	0.033	0.814	0.039	0.036	0	55	54.2	68.4	158	156	0	30	30
2015	7	2	13	56	52	0.174	0.052	0.814	0.039	0.039	0	53.8	52.5	69.2	155	151	0	30	29
2015	7	2	14	6	52	0.177	0.02	0.814	0.033	0.03	0	55	53.8	68.8	159	154	0	31	29
2015	7	2	14	16	52	0.148	-0.02	0.814	0.039	0.036	0	55	51.6	69.7	158	149	0	30	29
2015	7	2	14	26	52	0.138	-0.003	0.814	0.033	0.03	0	53.8	52.5	69.2	156	151	0	31	29
2015	7	2	14	36	52	0.154	-0.03	0.817	0.033	0.03	0	53.3	51.6	70.1	154	149	0	30	29
2015	7	2	14	46	52	0.18	0.079	0.817	0.039	0.036	0	53.3	52.5	69.7	154	151	0	30	29
2015	7	2	14	56	52	0.102	0.007	0.817	0.033	0.03	0	55	53.8	68.4	158	154	0	30	29
2015	7	2	15	6	52	0.167	0.072	0.817	0.033	0.033	0	54.2	53.3	69.7	156	153	0	30	29
2015	7	2	15	16	52	0.157	-0.013	0.817	0.036	0.033	0	54.2	52.9	69.2	156	152	0	30	29
2015	7	2	15	26	52	0.18	0.023	0.817	0.036	0.033	0	54.2	51.6	71	156	149	0	30	29
2015	7	2	15	36	52	0.075	0.059	0.817	0.036	0.033	0	51.2	49.9	71.8	149	145	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	2	15	46	52	0.154	-0.043	0.82	0.033	0.03	0	55	51.6	71.4	157	150	0	29	30
2015	7	2	15	56	52	0.092	0.01	0.82	0.039	0.039	0	54.2	52.9	70.1	156	152	0	30	29
2015	7	2	16	6	52	0.095	0.036	0.82	0.033	0.03	0	54.6	52.5	70.5	157	151	0	30	29
2015	7	2	16	16	52	0.157	0.007	0.82	0.036	0.033	0	53.3	52.9	71	154	152	0	30	29
2015	7	2	16	26	52	0.207	-0.01	0.82	0.033	0.03	0	53.8	52.5	71.4	155	151	0	30	29
2015	7	2	16	36	52	0.157	0.059	0.823	0.039	0.036	0	53.3	52	71.4	153	149	0	29	28
2015	7	2	16	46	52	0.164	-0.007	0.823	0.036	0.033	0	52.5	52.5	71.4	152	150	0	30	28
2015	7	2	16	56	52	0.128	0.016	0.823	0.033	0.03	0	53.3	51.6	70.1	154	149	0	30	29
2015	7	2	17	6	52	0.115	-0.016	0.823	0.033	0.03	0	52.9	52	71	153	149	0	30	28
2015	7	2	17	16	52	0.135	0.003	0.823	0.033	0.03	0	51.6	50.7	72.7	150	147	0	30	29
2015	7	2	17	26	52	0.131	-0.03	0.823	0.036	0.033	0	51.6	49.9	71.4	149	145	0	29	29
2015	7	2	17	36	52	0.135	0	0.823	0.039	0.036	0	49.9	48.2	73.1	146	141	0	30	29
2015	7	2	17	46	52	0.092	-0.069	0.823	0.039	0.039	0	48.6	47.7	73.5	143	139	0	30	28
2015	7	2	17	56	52	0.105	0.01	0.823	0.033	0.03	0	49	47.7	72.7	144	139	0	30	28
2015	7	2	18	6	52	0.089	-0.01	0.827	0.046	0.043	0	47.7	46.4	74	141	136	0	30	28
2015	7	2	18	16	52	0.125	-0.046	0.823	0.033	0.03	0	46.9	45.6	74.4	139	135	0	30	29
2015	7	2	18	26	52	0.19	-0.072	0.827	0.039	0.036	0	47.7	45.6	73.5	140	134	0	29	28
2015	7	2	18	36	52	0.138	0.026	0.827	0.033	0.03	0	46.9	44.7	74	138	133	0	29	29
2015	7	2	18	46	52	0.174	0.003	0.827	0.033	0.03	0	46.4	44.7	74	138	133	0	30	29
2015	7	2	18	56	52	0.03	-0.056	0.827	0.039	0.039	0	46.4	45.6	73.5	138	134	0	30	28
2015	7	2	19	6	52	0.112	0.066	0.827	0.039	0.036	0	46	45.6	73.5	137	135	0	30	29
2015	7	2	19	16	52	0.121	-0.033	0.827	0.036	0.033	0	46.9	45.6	73.5	139	134	0	30	28
2015	7	2	19	26	52	0.105	0	0.827	0.039	0.036	0	46.4	46	74.4	138	135	0	30	28
2015	7	2	19	36	52	0.174	0.036	0.827	0.039	0.036	0	46.4	45.6	72.7	138	135	0	30	29
2015	7	2	19	46	52	0.174	-0.036	0.827	0.039	0.039	0	47.3	46	72.7	140	136	0	30	29
2015	7	2	19	56	52	0.085	-0.043	0.827	0.033	0.03	0	48.2	46	72.2	141	136	0	29	29
2015	7	2	20	6	52	0.095	0.007	0.83	0.036	0.033	0	48.6	46.4	71.8	143	137	0	30	29
2015	7	2	20	16	52	0.174	-0.059	0.827	0.036	0.033	0	49.9	47.7	70.1	146	140	0	30	29
2015	7	2	20	26	52	0.115	0	0.83	0.039	0.039	0	49.5	48.2	70.5	145	140	0	30	28
2015	7	2	20	36	52	0.135	-0.016	0.83	0.033	0.03	0	49.5	47.7	69.7	145	140	0	30	29
2015	7	2	20	46	52	0.105	-0.01	0.83	0.039	0.036	0	50.7	48.6	69.2	147	143	0	29	30
2015	7	2	20	56	52	0.138	-0.092	0.83	0.039	0.036	0	49.9	48.2	69.2	146	141	0	30	29
2015	7	2	21	6	52	0.157	0.039	0.83	0.039	0.036	0	50.3	47.7	69.7	146	140	0	29	29
2015	7	2	21	16	52	0.115	0.046	0.83	0.036	0.033	0	50.7	48.2	70.1	147	141	0	29	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	2	21	26	52	0.135	-0.003	0.83	0.03	0.03	0	48.6	48.2	70.5	143	140	0	30	28
2015	7	2	21	36	52	0.184	0.072	0.83	0.039	0.039	0	49.5	47.3	71	144	138	0	29	28
2015	7	2	21	46	52	0.164	-0.007	0.83	0.043	0.039	0	49.5	48.2	70.1	145	141	0	30	29
2015	7	2	21	56	52	0.154	-0.125	0.83	0.039	0.036	0	49	47.3	70.5	144	139	0	30	29
2015	7	2	22	6	52	0.164	-0.052	0.83	0.039	0.036	0	48.6	46.9	69.7	143	138	0	30	29
2015	7	2	22	16	52	0.115	-0.075	0.83	0.036	0.033	0	48.6	47.3	70.5	143	139	0	30	29
2015	7	2	22	26	52	0.18	-0.023	0.83	0.033	0.03	0	49	47.3	71	143	139	0	29	29
2015	7	2	22	36	52	0.138	0	0.83	0.033	0.03	0	48.6	46.4	70.1	142	137	0	29	29
2015	7	2	22	46	52	0.164	-0.007	0.83	0.033	0.03	0	47.7	47.3	71	141	138	0	30	28
2015	7	2	22	56	52	0.154	-0.013	0.833	0.033	0.03	0	46.9	46	71	139	137	0	30	30
2015	7	2	23	6	52	0.141	-0.118	0.83	0.036	0.033	0	47.3	46.4	71.4	140	136	0	30	28
2015	7	2	23	16	52	0.095	0.007	0.83	0.039	0.036	0	47.3	45.6	70.5	140	135	0	30	29
2015	7	2	23	26	52	0.164	0	0.83	0.033	0.03	0	47.7	46.4	71	141	137	0	30	29
2015	7	2	23	36	52	0.102	-0.075	0.83	0.036	0.033	0	47.7	46.9	71.8	140	138	0	29	29
2015	7	2	23	46	52	0.072	-0.043	0.83	0.033	0.03	0	48.2	46.4	71.4	142	137	0	30	29
2015	7	2	23	56	52	0.102	-0.039	0.83	0.036	0.033	0	47.7	46.9	72.2	140	138	0	29	29
2015	7	3	0	6	52	0.174	-0.023	0.83	0.036	0.033	0	47.3	46	73.1	140	136	0	30	29
2015	7	3	0	16	52	0.092	0	0.83	0.033	0.03	0	46.9	45.6	71	139	136	0	30	30
2015	7	3	0	26	52	0.115	-0.016	0.83	0.033	0.03	0	47.3	45.6	73.1	139	135	0	29	29
2015	7	3	0	36	52	0.157	0.039	0.83	0.033	0.03	0	46	45.6	72.7	137	135	0	30	29
2015	7	3	0	46	52	0.115	0.036	0.83	0.033	0.03	0	46.9	44.7	72.2	139	134	0	30	30
2015	7	3	0	56	52	0.144	-0.066	0.83	0.036	0.033	0	46	45.2	72.7	137	134	0	30	29
2015	7	3	1	6	52	0.112	-0.059	0.827	0.033	0.03	0	46.9	45.6	72.7	139	135	0	30	29
2015	7	3	1	16	52	0.069	0	0.827	0.036	0.033	0	46.4	46.4	73.5	138	136	0	30	28
2015	7	3	1	26	52	0.135	-0.023	0.827	0.03	0.03	0	46.4	45.6	72.7	137	135	0	29	29
2015	7	3	1	36	52	0.151	-0.072	0.827	0.033	0.03	0	46.4	45.6	74	138	135	0	30	29
2015	7	3	1	46	52	0.187	0.108	0.823	0.033	0.03	0	60.6	59.8	51.2	171	168	0	30	29
2015	7	3	1	56	52	0.121	0.066	0.827	0.036	0.033	0	58	56.3	60.6	165	160	0	30	29
2015	7	3	2	6	52	0.141	0.131	0.823	0.036	0.033	0	59.3	57.2	56.3	168	162	0	30	29
2015	7	3	2	16	52	0.19	0.105	0.823	0.039	0.039	0	58	56.3	60.2	165	160	0	30	29
2015	7	3	2	26	52	0.226	0.18	0.823	0.043	0.039	0	57.6	55.9	61.5	164	159	0	30	29
2015	7	3	2	36	52	0.157	0.108	0.823	0.039	0.036	0	56.3	54.2	63.2	161	155	0	30	29
2015	7	3	2	46	52	0.19	0.171	0.823	0.033	0.03	0	54.6	53.3	65.4	157	153	0	30	29
2015	7	3	2	56	52	0.19	0.164	0.823	0.039	0.039	0	53.8	52	66.2	155	150	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	3	3	6	52	0.184	0.138	0.82	0.043	0.039	0	52.9	51.2	67.1	153	148	0	30	29
2015	7	3	3	16	52	0.131	0.069	0.82	0.039	0.036	0	52.5	50.7	67.5	152	147	0	30	29
2015	7	3	3	26	52	0.207	0.144	0.82	0.039	0.036	0	51.6	49.9	68.8	150	146	0	30	30
2015	7	3	3	36	52	0.184	0.151	0.82	0.039	0.036	0	51.6	49.5	68.8	150	144	0	30	29
2015	7	3	3	46	52	0.154	0.144	0.82	0.036	0.033	0	50.3	48.6	70.5	147	142	0	30	29
2015	7	3	3	56	52	0.151	0.144	0.82	0.036	0.033	0	49.9	48.2	70.5	146	141	0	30	29
2015	7	3	4	6	52	0.157	0.131	0.82	0.043	0.039	0	49.9	48.2	70.5	146	141	0	30	29
2015	7	3	4	16	52	0.131	0.151	0.82	0.039	0.039	0	49	47.7	71	144	140	0	30	29
2015	7	3	4	26	52	0.151	0.207	0.82	0.046	0.043	0	49	48.2	71	145	141	0	31	29
2015	7	3	4	36	52	0.226	0.052	0.82	0.039	0.036	0	50.7	48.6	69.7	148	143	0	30	30
2015	7	3	4	46	52	0.112	0.161	0.817	0.046	0.043	0	50.3	49.5	69.7	147	144	0	30	29
2015	7	3	4	56	52	0.213	0.236	0.817	0.039	0.039	0	49.9	48.6	70.1	146	142	0	30	29
2015	7	3	5	6	52	0.161	0.115	0.817	0.036	0.033	0	50.7	49	68.8	148	143	0	30	29
2015	7	3	5	16	52	0.213	0.164	0.817	0.033	0.03	0	50.7	49	68.8	148	143	0	30	29
2015	7	3	5	26	52	0.161	0.233	0.817	0.039	0.036	0	51.2	49.5	68.4	149	144	0	30	29
2015	7	3	5	36	52	0.161	0.21	0.814	0.039	0.036	0	51.2	49.5	68.8	149	144	0	30	29
2015	7	3	5	46	52	0.243	0.299	0.814	0.039	0.039	0	52	49.5	66.7	151	144	0	30	29
2015	7	3	5	56	52	0.243	0.23	0.814	0.043	0.039	0	51.6	49.5	67.5	150	144	0	30	29
2015	7	3	6	6	52	0.098	0.266	0.814	0.039	0.036	0	51.6	49.9	67.1	150	145	0	30	29
2015	7	3	6	16	52	0.125	0.223	0.814	0.043	0.039	0	51.6	49.5	67.1	150	144	0	30	29
2015	7	3	6	26	52	0.167	0.262	0.81	0.036	0.033	0	50.7	49	66.7	148	143	0	30	29
2015	7	3	6	36	52	0.144	0.256	0.81	0.039	0.036	0	50.7	49	66.2	148	143	0	30	29
2015	7	3	6	46	52	0.105	0.203	0.81	0.039	0.039	0	50.7	48.6	66.2	148	142	0	30	29
2015	7	3	6	56	52	0.171	0.289	0.81	0.039	0.036	0	50.3	48.2	67.1	147	142	0	30	30
2015	7	3	7	6	52	0.194	0.266	0.81	0.039	0.039	0	50.3	49	66.7	147	143	0	30	29
2015	7	3	7	16	52	0.171	0.207	0.807	0.049	0.046	0	49.9	48.2	66.7	146	141	0	30	29
2015	7	3	7	26	52	0.154	0.262	0.807	0.036	0.033	0	49.5	48.2	66.7	146	141	0	31	29
2015	7	3	7	36	52	0.138	0.256	0.807	0.036	0.033	0	50.3	48.2	66.2	147	142	0	30	30
2015	7	3	7	46	52	0.108	0.259	0.804	0.036	0.033	0	50.3	49	66.2	147	143	0	30	29
2015	7	3	7	56	52	0.144	0.24	0.804	0.033	0.03	0	50.7	49.5	67.1	148	144	0	30	29
2015	7	3	8	6	52	0.118	0.22	0.804	0.039	0.036	0	50.7	49	66.7	148	144	0	30	30
2015	7	3	8	16	52	0.174	0.141	0.801	0.033	0.03	0	50.7	49.9	66.7	148	145	0	30	29
2015	7	3	8	26	52	0.151	0.197	0.797	0.036	0.033	0	50.7	49	66.2	148	143	0	30	29
2015	7	3	8	36	52	0.089	0.194	0.797	0.043	0.039	0	50.3	48.6	65.8	147	142	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	3	8	46	52	0.187	0.108	0.794	0.039	0.036	0	50.3	49.5	66.7	147	144	0	30	29
2015	7	3	8	56	52	0.157	0.092	0.791	0.039	0.036	0	50.3	49.5	67.1	147	144	0	30	29
2015	7	3	9	6	52	0.21	0.138	0.791	0.046	0.043	0	49.9	49.9	68.8	146	145	0	30	29
2015	7	3	9	16	52	0.089	0.138	0.791	0.039	0.039	0	50.3	49.9	67.1	147	145	0	30	29
2015	7	3	9	26	52	0.108	0.187	0.791	0.039	0.039	0	50.3	49.9	68.4	147	145	0	30	29
2015	7	3	9	36	52	0.072	0.128	0.787	0.039	0.036	0	49.9	49.5	68.8	146	144	0	30	29
2015	7	3	9	46	52	0.115	0.089	0.787	0.033	0.03	0	50.7	49	69.7	148	143	0	30	29
2015	7	3	9	56	52	0.072	0.098	0.787	0.033	0.03	0	52	51.2	68.8	151	148	0	30	29
2015	7	3	10	6	52	0.089	0.121	0.787	0.033	0.03	0	52.9	50.7	68.4	153	147	0	30	29
2015	7	3	10	16	52	0.138	0.026	0.787	0.033	0.03	0	52	50.3	70.1	151	146	0	30	29
2015	7	3	10	26	52	0.148	0.085	0.787	0.036	0.033	0	52	49.9	69.7	151	145	0	30	29
2015	7	3	10	36	52	0.112	0.075	0.787	0.039	0.036	0	51.6	49	70.5	150	144	0	30	30
2015	7	3	10	46	52	0.131	0	0.787	0.036	0.033	0	51.6	50.3	71	150	146	0	30	29
2015	7	3	10	56	52	0.141	0.013	0.787	0.036	0.033	0	51.2	50.3	71.8	149	146	0	30	29
2015	7	3	11	6	52	0.141	0.085	0.787	0.033	0.03	0	51.2	50.7	71.8	149	147	0	30	29
2015	7	3	11	16	52	0.151	0.043	0.784	0.039	0.036	0	51.2	50.7	71.8	149	148	0	30	30
2015	7	3	11	26	52	0.157	-0.013	0.784	0.036	0.033	0	50.7	51.2	71	148	148	0	30	29
2015	7	3	11	36	52	0.043	0.098	0.784	0.033	0.03	0	49.9	51.2	72.2	146	148	0	30	29
2015	7	3	11	46	52	0.102	0	0.784	0.033	0.03	0	50.3	52	71.4	147	149	0	30	28
2015	7	3	11	56	52	0.105	0.082	0.784	0.033	0.03	0	52	52	71	151	150	0	30	29
2015	7	3	12	6	52	0.157	0.039	0.784	0.033	0.03	0	52.5	51.2	70.5	152	148	0	30	29
2015	7	3	12	16	52	0.036	0.023	0.781	0.036	0.033	0	51.2	52	71	149	150	0	30	29
2015	7	3	12	26	52	0.085	0.062	0.781	0.036	0.033	0	52	52.5	70.5	151	151	0	30	29
2015	7	3	12	36	52	0.131	0.075	0.784	0.039	0.036	0	52.9	52	69.7	152	150	0	29	29
2015	7	3	12	46	52	0.098	0.098	0.784	0.039	0.036	0	52.5	52.9	70.1	152	152	0	30	29
2015	7	3	12	56	52	0.164	0.079	0.784	0.033	0.03	0	52.9	52.9	70.5	153	152	0	30	29
2015	7	3	13	6	52	0.072	0.049	0.781	0.033	0.03	0	53.8	54.2	68.4	155	155	0	30	29
2015	7	3	13	16	52	0.066	0.089	0.784	0.036	0.033	0	54.2	53.8	68.4	156	154	0	30	29
2015	7	3	13	26	52	0.125	0.079	0.784	0.033	0.03	0	54.6	54.2	67.5	157	155	0	30	29
2015	7	3	13	36	52	0.154	0.098	0.787	0.036	0.033	0	54.2	54.6	67.5	157	155	0	31	28
2015	7	3	13	46	52	0.164	0.007	0.787	0.036	0.033	0	55.5	53.3	69.2	159	153	0	30	29
2015	7	3	13	56	52	0.095	0.075	0.787	0.036	0.033	0	55	54.2	68.4	158	154	0	30	28
2015	7	3	14	6	52	0.062	0.052	0.787	0.036	0.033	0	55.5	52.5	68.8	159	151	0	30	29
2015	7	3	14	16	52	0.075	0.023	0.787	0.036	0.033	0	55.9	53.8	68.4	160	154	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	3	14	26	52	0.112	0.098	0.787	0.036	0.033	0	55.5	53.3	67.9	159	153	0	30	29
2015	7	3	14	36	52	0.098	0.036	0.787	0.043	0.039	0	55.5	53.8	67.9	158	154	0	29	29
2015	7	3	14	46	52	0.075	0.062	0.791	0.036	0.033	0	54.6	55	67.1	157	156	0	30	28
2015	7	3	14	56	52	0.138	0.049	0.791	0.036	0.033	0	54.6	53.3	68.8	157	152	0	30	28
2015	7	3	15	6	52	0.125	-0.007	0.791	0.033	0.03	0	55.5	53.8	68.4	159	153	0	30	28
2015	7	3	15	16	52	0.089	0.003	0.791	0.039	0.036	0	55.5	54.2	67.1	158	155	0	29	29
2015	7	3	15	26	52	0.138	0.016	0.791	0.039	0.036	0	55.5	53.8	66.7	159	154	0	30	29
2015	7	3	15	36	52	0.138	0	0.791	0.039	0.036	0	56.3	54.2	66.7	160	155	0	29	29
2015	7	3	15	46	52	0.118	0.075	0.794	0.033	0.03	0	55.5	54.6	66.7	158	156	0	29	29
2015	7	3	15	56	52	0.089	0.118	0.794	0.033	0.03	0	54.6	53.8	66.7	157	154	0	30	29
2015	7	3	16	6	52	0.112	0.098	0.794	0.033	0.03	0	55.5	54.6	64.1	158	155	0	29	28
2015	7	3	16	16	52	0.118	0.089	0.797	0.043	0.043	0	54.2	52.9	66.2	155	151	0	29	28
2015	7	3	16	26	52	0.085	-0.007	0.797	0.036	0.033	0	51.2	51.2	67.9	148	147	0	29	28
2015	7	3	16	36	52	0.082	0.02	0.797	0.043	0.039	0	50.7	49.5	67.9	147	143	0	29	28
2015	7	3	16	46	52	0.066	0.016	0.801	0.039	0.039	0	51.6	49.5	67.1	149	144	0	29	29
2015	7	3	16	56	52	0.157	-0.016	0.804	0.033	0.03	0	47.7	48.2	68.4	141	140	0	30	28
2015	7	3	17	6	52	0.095	0.01	0.804	0.033	0.03	0	51.6	49.9	67.5	149	145	0	29	29
2015	7	3	17	16	52	0.18	0.036	0.807	0.036	0.033	0	49.5	49	67.5	144	142	0	29	28
2015	7	3	17	26	52	0.174	0.01	0.81	0.039	0.036	0	50.3	49.5	68.4	146	143	0	29	28
2015	7	3	17	36	52	0.2	0.059	0.814	0.033	0.03	0	49	48.2	68.4	143	140	0	29	28
2015	7	3	17	46	52	0.089	0	0.814	0.036	0.033	0	49	47.3	69.2	143	138	0	29	28
2015	7	3	17	56	52	0.141	-0.043	0.817	0.039	0.039	0	47.7	46.9	69.7	141	138	0	30	29
2015	7	3	18	6	52	0.102	-0.02	0.817	0.036	0.033	0	49	46.9	70.1	143	138	0	29	29
2015	7	3	18	16	52	0.289	0.013	0.817	0.036	0.033	0	47.3	46	71	139	135	0	29	28
2015	7	3	18	26	52	0.141	-0.03	0.82	0.033	0.03	0	46.4	45.6	72.7	137	134	0	29	28
2015	7	3	18	36	52	0.075	0.095	0.82	0.039	0.039	0	46.4	44.3	72.7	137	132	0	29	29
2015	7	3	18	46	52	0.187	-0.007	0.82	0.036	0.033	0	46	44.3	72.7	136	132	0	29	29
2015	7	3	18	56	52	0.236	-0.033	0.82	0.039	0.036	0	46.9	44.3	72.2	138	131	0	29	28
2015	7	3	19	6	52	0.128	-0.01	0.82	0.039	0.039	0	45.6	44.7	74	135	132	0	29	28
2015	7	3	19	16	52	0.079	0.03	0.823	0.039	0.036	0	45.2	44.3	74	134	131	0	29	28
2015	7	3	19	26	52	0.138	0.056	0.823	0.039	0.036	0	46	44.7	74	136	132	0	29	28
2015	7	3	19	36	52	0.036	-0.02	0.823	0.039	0.036	0	47.3	44.7	73.1	140	133	0	30	29
2015	7	3	19	46	52	0.164	-0.03	0.823	0.039	0.039	0	48.2	46.4	71.8	142	137	0	30	29
2015	7	3	19	56	52	0.118	-0.026	0.823	0.036	0.033	0	49	46.9	71.4	144	138	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	3	20	6	52	0.121	0.01	0.823	0.039	0.039	0	49.5	46.9	71.8	144	137	0	29	28
2015	7	3	20	16	52	0.121	-0.072	0.827	0.039	0.039	0	48.2	46.4	72.7	141	136	0	29	28
2015	7	3	20	26	52	0.141	0	0.827	0.039	0.036	0	49.5	46	72.2	144	136	0	29	29
2015	7	3	20	36	52	0.148	0.013	0.827	0.039	0.036	0	49.5	47.3	71.4	144	138	0	29	28
2015	7	3	20	46	52	0.164	0	0.827	0.039	0.039	0	50.7	48.2	69.2	147	141	0	29	29
2015	7	3	20	56	52	0.135	-0.033	0.827	0.036	0.033	0	49.9	47.7	71.4	145	140	0	29	29
2015	7	3	21	6	52	0.105	-0.033	0.827	0.033	0.03	0	49	47.3	70.5	143	139	0	29	29
2015	7	3	21	16	52	0.121	-0.079	0.827	0.036	0.033	0	49	47.3	71.4	144	139	0	30	29
2015	7	3	21	26	52	0.079	-0.075	0.827	0.036	0.033	0	49	47.7	71.4	144	140	0	30	29
2015	7	3	21	36	52	0.105	-0.056	0.827	0.046	0.046	0	47.7	46.4	72.7	141	136	0	30	28
2015	7	3	21	46	52	0.098	0.049	0.827	0.039	0.036	0	47.3	45.6	74	140	135	0	30	29
2015	7	3	21	56	52	0.151	-0.072	0.827	0.033	0.03	0	47.3	46	73.5	140	136	0	30	29
2015	7	3	22	6	52	0.177	0.01	0.827	0.036	0.033	0	46	46	73.1	137	135	0	30	28
2015	7	3	22	16	52	0.19	-0.016	0.827	0.033	0.03	0	46.9	45.6	73.5	139	135	0	30	29
2015	7	3	22	26	52	0.171	0	0.827	0.036	0.033	0	47.3	46.4	74	139	136	0	29	28
2015	7	3	22	36	52	0.108	-0.059	0.827	0.033	0.03	0	46.4	46	74.4	138	136	0	30	29
2015	7	3	22	46	52	0.128	0.003	0.827	0.036	0.033	0	47.3	46.4	73.5	140	136	0	30	28
2015	7	3	22	56	52	0.112	-0.016	0.827	0.039	0.039	0	49.5	46.4	72.7	144	137	0	29	29
2015	7	3	23	6	52	0.154	-0.043	0.827	0.036	0.033	0	47.3	46.4	73.1	140	137	0	30	29
2015	7	3	23	16	52	0.075	0.003	0.827	0.049	0.046	0	47.7	46	72.2	141	136	0	30	29
2015	7	3	23	26	52	0.154	-0.082	0.827	0.039	0.039	0	48.6	46.9	71.8	143	138	0	30	29
2015	7	3	23	36	52	0.197	-0.056	0.827	0.039	0.036	0	47.3	46	73.1	140	136	0	30	29
2015	7	3	23	46	52	0.108	-0.075	0.827	0.036	0.033	0	49.9	48.2	70.5	146	140	0	30	28
2015	7	3	23	56	52	0.112	-0.059	0.827	0.036	0.033	0	48.2	47.3	71.4	142	138	0	30	28
2015	7	4	0	6	52	0.095	-0.059	0.827	0.036	0.033	0	46.9	46.4	72.7	139	137	0	30	29
2015	7	4	0	16	52	0.056	0.007	0.83	0.039	0.039	0	48.2	46.9	71.8	142	138	0	30	29
2015	7	4	0	26	52	0.079	-0.059	0.827	0.039	0.039	0	52.9	50.7	66.7	153	147	0	30	29
2015	7	4	0	36	52	0.131	0.039	0.827	0.039	0.036	0	49.9	48.6	69.7	145	142	0	29	29
2015	7	4	0	46	52	0.151	0	0.827	0.033	0.03	0	52	50.7	67.5	151	146	0	30	28
2015	7	4	0	56	52	0.161	0.033	0.827	0.036	0.033	0	50.7	49.9	69.2	148	144	0	30	28
2015	7	4	1	6	52	0.135	0.052	0.827	0.033	0.03	0	48.6	47.7	70.5	143	140	0	30	29
2015	7	4	1	16	52	0.128	-0.01	0.827	0.036	0.033	0	47.7	46.9	71.8	141	138	0	30	29
2015	7	4	1	26	52	0.157	0	0.827	0.036	0.033	0	46.9	46	71.8	139	137	0	30	30
2015	7	4	1	36	52	0.154	0	0.827	0.036	0.033	0	46.9	45.6	72.2	139	135	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	4	1	46	52	0.135	0	0.827	0.036	0.033	0	46	44.7	72.7	137	133	0	30	29
2015	7	4	1	56	52	0.194	0	0.827	0.036	0.033	0	46.4	46.4	71.8	138	137	0	30	29
2015	7	4	2	6	52	0.079	0.013	0.827	0.039	0.039	0	46.9	46	72.7	139	136	0	30	29
2015	7	4	2	16	52	0.092	-0.039	0.827	0.036	0.033	0	46.9	46.4	71.4	139	137	0	30	29
2015	7	4	2	26	52	0.112	-0.036	0.827	0.036	0.033	0	46	45.6	72.7	137	135	0	30	29
2015	7	4	2	36	52	0.148	-0.079	0.827	0.033	0.03	0	46.9	46.4	72.7	139	137	0	30	29
2015	7	4	2	46	52	0.135	-0.013	0.827	0.039	0.036	0	46.4	45.2	74	137	134	0	29	29
2015	7	4	2	56	52	0.115	-0.02	0.827	0.033	0.03	0	46.9	44.7	73.5	138	133	0	29	29
2015	7	4	3	6	52	0.115	-0.003	0.827	0.036	0.033	0	46.4	45.2	73.1	138	134	0	30	29
2015	7	4	3	16	52	0.092	-0.013	0.823	0.033	0.03	0	44.3	44.7	74.4	133	133	0	30	29
2015	7	4	3	26	52	0.095	-0.02	0.823	0.033	0.03	0	44.3	44.7	73.5	133	133	0	30	29
2015	7	4	3	36	52	0.2	0	0.823	0.033	0.03	0	49.5	48.2	69.7	145	141	0	30	29
2015	7	4	3	46	52	0.049	-0.016	0.823	0.033	0.03	0	45.2	44.7	74.4	135	133	0	30	29
2015	7	4	3	56	52	0.112	0.098	0.823	0.033	0.03	0	48.6	48.6	71	143	142	0	30	29
2015	7	4	4	6	52	0.125	0.062	0.823	0.036	0.033	0	49.5	48.2	69.7	145	141	0	30	29
2015	7	4	4	16	52	0.243	0.046	0.823	0.033	0.03	0	48.6	47.3	70.5	143	139	0	30	29
2015	7	4	4	26	52	0.151	0.026	0.823	0.039	0.036	0	46.9	45.6	72.7	139	135	0	30	29
2015	7	4	4	36	52	0.19	-0.007	0.823	0.036	0.033	0	46	45.2	74.8	137	134	0	30	29
2015	7	4	4	46	52	0.184	-0.049	0.823	0.033	0.033	0	46	45.2	74	137	134	0	30	29
2015	7	4	4	56	52	0.161	-0.066	0.82	0.039	0.039	0	44.7	44.3	74.4	134	133	0	30	30
2015	7	4	5	6	52	0.092	-0.03	0.82	0.033	0.03	0	44.3	43.9	74.4	133	131	0	30	29
2015	7	4	5	16	52	0.108	0.052	0.82	0.036	0.033	0	45.2	43.9	74	135	130	0	30	28
2015	7	4	5	26	52	0.128	-0.023	0.82	0.036	0.033	0	44.7	43.9	74.8	134	131	0	30	29
2015	7	4	5	36	52	0.141	0.052	0.82	0.036	0.033	0	45.6	44.3	75.3	136	132	0	30	29
2015	7	4	5	46	52	0.102	-0.023	0.82	0.036	0.033	0	44.7	43.9	74.8	134	131	0	30	29
2015	7	4	5	56	52	0.112	-0.039	0.82	0.039	0.039	0	45.2	44.3	74	135	132	0	30	29
2015	7	4	6	6	52	0.157	-0.013	0.82	0.039	0.036	0	45.6	43.9	74.4	136	132	0	30	30
2015	7	4	6	16	52	0.118	-0.007	0.82	0.036	0.033	0	44.3	42.6	75.7	133	129	0	30	30
2015	7	4	6	26	52	0.112	-0.043	0.82	0.033	0.03	0	43.9	43.4	75.3	132	130	0	30	29
2015	7	4	6	36	52	0.085	-0.052	0.817	0.036	0.033	0	44.7	43.9	74.8	134	131	0	30	29
2015	7	4	6	46	52	0.128	0	0.82	0.033	0.03	0	42.1	42.1	76.5	128	127	0	30	29
2015	7	4	6	56	52	0.154	-0.056	0.817	0.036	0.033	0	43.4	43.4	75.3	131	130	0	30	29
2015	7	4	7	6	52	0.121	-0.033	0.817	0.033	0.03	0	43.9	43	75.7	131	129	0	29	29
2015	7	4	7	16	52	0.151	-0.075	0.817	0.036	0.033	0	43	42.6	76.1	130	128	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	4	7	26	52	0.148	-0.023	0.817	0.033	0.03	0	43.9	43.4	76.1	132	130	0	30	29
2015	7	4	7	36	52	0.161	0.016	0.817	0.036	0.033	0	42.6	43	75.7	129	129	0	30	29
2015	7	4	7	46	52	0.135	0	0.817	0.039	0.036	0	42.6	42.6	75.7	129	128	0	30	29
2015	7	4	7	56	52	0.128	-0.082	0.817	0.039	0.036	0	44.3	42.6	74.8	133	128	0	30	29
2015	7	4	8	6	52	0.121	-0.039	0.817	0.033	0.03	0	43.9	43.4	75.3	132	130	0	30	29
2015	7	4	8	16	52	0.151	-0.056	0.814	0.033	0.03	0	43.4	43.4	74.8	132	130	0	31	29
2015	7	4	8	26	52	0.112	-0.062	0.814	0.036	0.033	0	43.9	42.6	74	132	129	0	30	30
2015	7	4	8	36	52	0.207	-0.108	0.814	0.039	0.036	0	43.9	43.4	73.5	132	131	0	30	30
2015	7	4	8	46	52	0.105	-0.072	0.814	0.039	0.039	0	44.3	44.3	74	133	132	0	30	29
2015	7	4	8	56	52	0.007	-0.016	0.814	0.039	0.036	0	46.9	46	71.4	140	136	0	31	29
2015	7	4	9	6	52	0.062	-0.036	0.814	0.036	0.033	0	45.2	43.4	74.4	135	131	0	30	30
2015	7	4	9	16	52	0.108	-0.046	0.81	0.039	0.036	0	46	44.7	72.2	137	134	0	30	30
2015	7	4	9	26	52	0.102	0	0.81	0.033	0.03	0	46	44.7	71.8	137	134	0	30	30
2015	7	4	9	36	52	0.148	0.007	0.81	0.036	0.033	0	45.2	43.9	71.8	135	132	0	30	30
2015	7	4	9	46	52	0.052	-0.02	0.81	0.039	0.036	0	46.9	45.6	71	139	135	0	30	29
2015	7	4	9	56	52	0.102	0	0.81	0.033	0.03	0	46	46	70.5	137	136	0	30	29
2015	7	4	10	6	52	0.135	0.03	0.81	0.033	0.03	0	47.7	46.9	71.4	141	138	0	30	29
2015	7	4	10	16	52	0.052	-0.01	0.81	0.033	0.03	0	48.2	48.6	69.7	142	142	0	30	29
2015	7	4	10	26	52	0.052	0	0.807	0.036	0.033	0	48.6	48.2	70.1	143	141	0	30	29
2015	7	4	10	36	52	0.075	-0.01	0.807	0.033	0.03	0	49.5	48.6	69.7	145	142	0	30	29
2015	7	4	10	46	52	0.095	0.016	0.807	0.036	0.033	0	47.7	49	69.7	141	143	0	30	29
2015	7	4	10	56	52	0.157	-0.007	0.807	0.033	0.03	0	48.6	48.2	69.7	143	142	0	30	30
2015	7	4	11	6	52	0.118	0.046	0.807	0.036	0.033	0	49.9	49.5	68.8	146	144	0	30	29
2015	7	4	11	16	52	0.03	0	0.804	0.039	0.036	0	48.2	47.7	69.2	142	140	0	30	29
2015	7	4	11	26	52	0.157	0.036	0.801	0.033	0.03	0	50.7	49.9	68.8	148	145	0	30	29
2015	7	4	11	36	52	0.105	0.036	0.797	0.039	0.039	0	50.7	50.3	68.8	148	146	0	30	29
2015	7	4	11	46	52	0.039	0.023	0.801	0.033	0.03	0	50.3	50.7	68.4	147	147	0	30	29
2015	7	4	11	56	52	0.102	0.075	0.797	0.033	0.03	0	48.6	49.9	69.7	144	145	0	31	29
2015	7	4	12	6	52	0.108	0.013	0.797	0.033	0.03	0	51.6	52	68.4	150	150	0	30	29
2015	7	4	12	16	52	0.164	0.03	0.797	0.033	0.03	0	52	52	68.8	151	151	0	30	30
2015	7	4	12	26	52	0.092	0.023	0.794	0.036	0.033	0	50.7	51.6	67.5	149	149	0	31	29
2015	7	4	12	36	52	0.102	0	0.794	0.033	0.03	0	51.2	51.6	68.8	149	149	0	30	29
2015	7	4	12	46	52	0.112	0.036	0.794	0.033	0.03	0	52.9	52	67.5	153	150	0	30	29
2015	7	4	12	56	52	0.092	0.062	0.794	0.033	0.03	0	53.8	53.8	67.5	155	154	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	4	13	6	52	0.151	0.098	0.791	0.033	0.033	0	53.8	52.5	67.9	155	151	0	30	29
2015	7	4	13	16	52	0.125	0.023	0.791	0.033	0.033	0	54.2	52.5	66.7	156	152	0	30	30
2015	7	4	13	26	52	0.085	0.039	0.794	0.033	0.03	0	53.3	53.3	66.2	154	153	0	30	29
2015	7	4	13	36	52	0.154	0.02	0.791	0.036	0.033	0	54.2	53.3	67.1	156	152	0	30	28
2015	7	4	13	46	52	0.075	0.023	0.794	0.033	0.03	0	54.6	53.3	66.2	157	153	0	30	29
2015	7	4	13	56	52	0.075	0.075	0.794	0.036	0.033	0	54.6	55	66.2	157	157	0	30	29
2015	7	4	14	6	52	0.128	0.059	0.791	0.033	0.03	0	55	54.6	66.2	158	156	0	30	29
2015	7	4	14	16	52	0.174	0.049	0.791	0.033	0.033	0	53.8	52.9	67.5	155	152	0	30	29
2015	7	4	14	26	52	0.154	0.062	0.791	0.036	0.033	0	54.6	54.2	67.1	157	155	0	30	29
2015	7	4	14	36	52	0.141	0.03	0.794	0.033	0.03	0	55.5	53.8	68.8	159	154	0	30	29
2015	7	4	14	46	52	0.092	0.039	0.791	0.036	0.033	0	53.8	54.2	67.5	155	155	0	30	29
2015	7	4	14	56	52	0.095	0.013	0.791	0.033	0.03	0	51.2	52	70.5	149	150	0	30	29
2015	7	4	15	6	52	0.112	0.016	0.791	0.033	0.03	0	54.2	54.2	66.2	156	155	0	30	29
2015	7	4	15	16	52	0.069	0.03	0.794	0.036	0.033	0	52.5	52.5	69.2	152	151	0	30	29
2015	7	4	15	26	52	0.075	0.079	0.791	0.033	0.03	0	50.7	51.2	69.2	148	148	0	30	29
2015	7	4	15	36	52	0.148	0.016	0.794	0.036	0.033	0	52.5	50.3	67.1	151	146	0	29	29
2015	7	4	15	46	52	0.144	-0.003	0.794	0.033	0.03	0	54.2	51.6	68.4	155	149	0	29	29
2015	7	4	15	56	52	0.138	0.059	0.794	0.039	0.036	0	55.5	53.8	65.4	158	154	0	29	29
2015	7	4	16	6	52	0.128	0	0.794	0.039	0.036	0	53.3	52.5	67.5	154	150	0	30	28
2015	7	4	16	16	52	0.036	0.125	0.794	0.033	0.03	0	48.6	49.5	68.8	143	144	0	30	29
2015	7	4	16	26	52	0.039	0.062	0.794	0.039	0.036	0	48.6	46.9	68.4	143	137	0	30	28
2015	7	4	16	36	52	0.203	0.016	0.791	0.039	0.039	0	50.7	48.2	65.4	148	141	0	30	29
2015	7	4	16	46	52	0.164	-0.059	0.791	0.036	0.033	0	51.6	49.5	64.9	150	144	0	30	29
2015	7	4	16	56	52	0.095	0.052	0.794	0.036	0.033	0	52.5	50.3	64.9	151	146	0	29	29
2015	7	4	17	6	52	0.089	0.016	0.797	0.039	0.036	0	52.9	50.7	63.6	153	146	0	30	28
2015	7	4	17	16	52	0.226	0.115	0.797	0.039	0.039	0	52.9	51.6	64.1	153	149	0	30	29
2015	7	4	17	26	52	0.174	0.059	0.797	0.033	0.03	0	53.8	52.5	63.2	155	151	0	30	29
2015	7	4	17	36	52	0.135	0.023	0.801	0.039	0.039	0	53.8	52	64.5	155	149	0	30	28
2015	7	4	17	46	52	0.089	0.075	0.804	0.036	0.033	0	51.6	51.6	65.4	150	149	0	30	29
2015	7	4	17	56	52	0.105	0.049	0.807	0.046	0.043	0	51.6	49.9	66.7	150	146	0	30	30
2015	7	4	18	6	52	0.112	0.059	0.797	0.036	0.033	0	56.3	54.2	58.9	161	154	0	30	28
2015	7	4	18	16	52	0.115	0.135	0.807	0.043	0.039	0	58	56.3	58.9	165	159	0	30	28
2015	7	4	18	26	52	0.135	0.052	0.81	0.039	0.039	0	55.5	53.8	62.8	159	154	0	30	29
2015	7	4	18	36	52	0.141	0.085	0.81	0.036	0.033	0	55.9	53.8	61.5	160	154	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	4	18	46	52	0.174	0.02	0.81	0.036	0.033	0	56.3	53.8	62.4	160	154	0	29	29
2015	7	4	18	56	52	0.121	0.075	0.814	0.033	0.03	0	53.3	51.2	64.5	154	148	0	30	29
2015	7	4	19	6	52	0.135	0.059	0.814	0.043	0.039	0	53.8	51.2	64.5	154	148	0	29	29
2015	7	4	19	16	52	0.056	0.075	0.814	0.033	0.03	0	52	50.7	65.8	151	147	0	30	29
2015	7	4	19	26	52	0.089	0.075	0.81	0.039	0.036	0	52.9	51.2	63.2	153	148	0	30	29
2015	7	4	19	36	52	0.135	0	0.814	0.036	0.033	0	53.8	51.6	64.1	154	149	0	29	29
2015	7	4	19	46	52	0.115	-0.026	0.814	0.039	0.039	0	55.5	53.3	62.8	159	153	0	30	29
2015	7	4	19	56	52	0.121	-0.016	0.817	0.039	0.039	0	56.3	53.8	63.6	161	154	0	30	29
2015	7	4	20	6	52	0.098	-0.01	0.817	0.039	0.039	0	54.6	52.5	64.5	157	151	0	30	29
2015	7	4	20	16	52	0.167	0.01	0.817	0.039	0.036	0	54.2	52.9	64.9	156	151	0	30	28
2015	7	4	20	26	52	0.056	-0.016	0.817	0.036	0.033	0	53.3	51.6	65.8	154	149	0	30	29
2015	7	4	20	36	52	0.135	-0.026	0.82	0.043	0.039	0	55.9	53.3	64.1	159	153	0	29	29
2015	7	4	20	46	52	0.128	0.01	0.82	0.043	0.039	0	57.2	54.6	62.4	162	156	0	29	29
2015	7	4	20	56	52	0.118	-0.056	0.82	0.036	0.033	0	55	52.5	64.9	158	151	0	30	29
2015	7	4	21	6	52	0.072	-0.072	0.82	0.039	0.039	0	54.6	52.5	64.9	157	151	0	30	29
2015	7	4	21	16	52	0.112	0	0.82	0.039	0.039	0	54.2	51.6	65.8	156	149	0	30	29
2015	7	4	21	26	52	0.102	-0.013	0.82	0.039	0.036	0	52.5	50.3	68.4	152	145	0	30	28
2015	7	4	21	36	52	0.164	-0.039	0.82	0.033	0.03	0	52.5	50.7	68.4	152	147	0	30	29
2015	7	4	21	46	52	0.089	-0.033	0.82	0.043	0.039	0	53.3	51.2	67.5	154	148	0	30	29
2015	7	4	21	56	52	0.171	0.013	0.82	0.039	0.036	0	50.7	49	70.5	148	143	0	30	29
2015	7	4	22	6	52	0.036	-0.026	0.82	0.039	0.036	0	50.7	48.6	70.1	148	142	0	30	29
2015	7	4	22	16	52	0.138	0.033	0.82	0.049	0.046	0	52.9	51.2	67.5	153	147	0	30	28
2015	7	4	22	26	52	0.112	0.026	0.82	0.033	0.03	0	50.3	49.5	70.1	147	143	0	30	28
2015	7	4	22	36	52	0.213	-0.02	0.82	0.043	0.039	0	50.7	49	70.1	148	143	0	30	29
2015	7	4	22	46	52	0.095	0.052	0.82	0.033	0.03	0	49.5	47.7	71.8	144	140	0	29	29
2015	7	4	22	56	52	0.112	0.049	0.82	0.036	0.033	0	50.3	49	71	146	142	0	29	28
2015	7	4	23	6	52	0.056	0.016	0.82	0.036	0.033	0	48.6	47.7	72.2	143	140	0	30	29
2015	7	4	23	16	52	0.138	-0.026	0.82	0.039	0.039	0	49.5	47.3	70.5	145	139	0	30	29
2015	7	4	23	26	52	0.062	0.016	0.82	0.033	0.03	0	49	47.7	71.4	144	140	0	30	29
2015	7	4	23	36	52	0.125	0.039	0.82	0.039	0.036	0	49.5	47.7	72.2	145	141	0	30	30
2015	7	4	23	46	52	0.082	0.01	0.82	0.039	0.036	0	49.9	48.2	71.4	145	141	0	29	29
2015	7	4	23	56	52	0.194	-0.043	0.82	0.036	0.033	0	49.5	47.3	72.2	144	139	0	29	29
2015	7	5	0	6	52	0.072	0.02	0.82	0.039	0.039	0	48.6	47.7	72.2	144	140	0	31	29
2015	7	5	0	16	52	0.154	0.033	0.82	0.033	0.03	0	46.9	46.9	73.1	139	138	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	5	0	26	52	0.177	-0.056	0.823	0.033	0.03	0	46.4	46.9	73.1	139	137	0	31	28
2015	7	5	0	36	52	0.118	-0.007	0.823	0.036	0.033	0	46.9	45.6	73.5	139	135	0	30	29
2015	7	5	0	46	52	0.174	-0.02	0.823	0.039	0.039	0	46	46	72.7	137	136	0	30	29
2015	7	5	0	56	52	0.072	-0.059	0.823	0.039	0.039	0	46.9	46	72.7	138	136	0	29	29
2015	7	5	1	6	52	0.187	-0.03	0.823	0.036	0.033	0	47.3	46.9	72.7	140	138	0	30	29
2015	7	5	1	16	52	0.167	0.01	0.823	0.039	0.036	0	46	45.6	72.7	138	136	0	31	30
2015	7	5	1	26	52	0.151	0.036	0.823	0.033	0.033	0	46.9	46.4	71.4	139	137	0	30	29
2015	7	5	1	36	52	0.098	-0.02	0.823	0.036	0.033	0	46.4	46	72.7	139	136	0	31	29
2015	7	5	1	46	52	0.144	-0.072	0.827	0.033	0.03	0	46.9	46.4	73.1	139	137	0	30	29
2015	7	5	1	56	52	0.082	-0.039	0.827	0.036	0.033	0	46.9	46	71.8	139	136	0	30	29
2015	7	5	2	6	52	0.148	-0.03	0.827	0.039	0.039	0	46	45.2	72.2	137	134	0	30	29
2015	7	5	2	16	52	0.128	0.069	0.827	0.036	0.033	0	45.6	46	71.8	137	136	0	31	29
2015	7	5	2	26	52	0.151	-0.023	0.827	0.033	0.033	0	46	45.6	71.4	137	135	0	30	29
2015	7	5	2	36	52	0.125	0	0.83	0.036	0.033	0	46.4	45.6	71.8	138	135	0	30	29
2015	7	5	2	46	52	0.141	-0.036	0.83	0.036	0.033	0	46.4	46.9	69.7	138	138	0	30	29
2015	7	5	2	56	52	0.148	-0.033	0.83	0.036	0.033	0	45.6	45.6	71.4	137	135	0	31	29
2015	7	5	3	6	52	0.075	-0.043	0.833	0.036	0.033	0	45.2	44.7	71	136	134	0	31	30
2015	7	5	3	16	52	0.105	-0.003	0.837	0.036	0.033	0	45.2	44.3	71	135	133	0	30	30
2015	7	5	3	26	52	0.115	0	0.837	0.039	0.036	0	46	44.7	71	137	134	0	30	30
2015	7	5	3	36	52	0.089	0.026	0.84	0.033	0.03	0	45.6	44.3	71.4	137	133	0	31	30
2015	7	5	3	46	52	0.164	0.016	0.84	0.039	0.036	0	45.2	43.9	71.8	135	132	0	30	30
2015	7	5	3	56	52	0.148	-0.02	0.843	0.039	0.039	0	43.9	43.9	71.4	133	132	0	31	30
2015	7	5	4	6	52	0.128	-0.089	0.843	0.039	0.036	0	45.2	43.9	71.8	136	132	0	31	30
2015	7	5	4	16	52	0.184	-0.089	0.843	0.033	0.03	0	44.7	45.2	71.8	135	134	0	31	29
2015	7	5	4	26	52	0.125	0.013	0.846	0.039	0.036	0	44.7	44.3	72.7	134	133	0	30	30
2015	7	5	4	36	52	0.121	-0.049	0.846	0.039	0.036	0	44.7	44.3	73.1	135	132	0	31	29
2015	7	5	4	46	52	0.21	-0.02	0.846	0.036	0.033	0	45.2	44.3	73.1	135	132	0	30	29
2015	7	5	4	56	52	0.184	-0.062	0.846	0.036	0.033	0	45.2	44.3	72.7	135	133	0	30	30
2015	7	5	5	6	52	0.121	-0.026	0.846	0.033	0.03	0	45.6	44.3	73.1	136	133	0	30	30
2015	7	5	5	16	52	0.085	0.036	0.85	0.033	0.03	0	45.2	44.3	73.5	135	133	0	30	30
2015	7	5	5	26	52	0.167	0.013	0.85	0.036	0.033	0	44.7	43.9	73.5	134	132	0	30	30
2015	7	5	5	36	52	0.118	-0.007	0.85	0.033	0.03	0	45.2	44.3	74.8	135	132	0	30	29
2015	7	5	5	46	52	0.108	0.02	0.85	0.039	0.036	0	45.2	43.4	74	136	131	0	31	30
2015	7	5	5	56	52	0.157	-0.007	0.85	0.036	0.033	0	43.4	43.4	75.3	132	130	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	5	6	6	52	0.121	-0.049	0.85	0.033	0.03	0	44.7	43	74.8	134	130	0	30	30
2015	7	5	6	16	52	0.052	-0.01	0.85	0.036	0.033	0	46.4	44.3	72.7	138	133	0	30	30
2015	7	5	6	26	52	0.115	-0.016	0.85	0.039	0.036	0	46.4	45.2	72.2	138	135	0	30	30
2015	7	5	6	36	52	0.141	-0.075	0.85	0.039	0.039	0	46.9	44.7	72.7	140	135	0	31	31
2015	7	5	6	46	52	0.177	-0.089	0.85	0.039	0.036	0	46.9	46	72.2	140	136	0	31	29
2015	7	5	6	56	52	0.203	-0.01	0.853	0.036	0.033	0	46.4	44.3	73.1	138	133	0	30	30
2015	7	5	7	6	52	0.118	-0.007	0.853	0.039	0.036	0	46.4	45.2	73.5	139	135	0	31	30
2015	7	5	7	16	52	0.118	-0.079	0.853	0.043	0.039	0	46.4	45.2	72.7	139	135	0	31	30
2015	7	5	7	26	52	0.194	-0.003	0.853	0.039	0.036	0	46.9	45.6	73.5	139	136	0	30	30
2015	7	5	7	36	52	0.138	-0.033	0.853	0.036	0.033	0	46.4	44.3	74	138	133	0	30	30
2015	7	5	7	46	52	0.19	-0.069	0.853	0.039	0.039	0	48.6	46.9	72.7	144	138	0	31	29
2015	7	5	7	56	52	0.148	-0.049	0.853	0.039	0.036	0	47.3	47.7	73.1	141	140	0	31	29
2015	7	5	8	6	52	0.144	0.072	0.853	0.039	0.036	0	49	48.6	71.8	145	142	0	31	29
2015	7	5	8	16	52	0.253	0.03	0.853	0.039	0.036	0	48.6	49	71.4	144	144	0	31	30
2015	7	5	8	26	52	0.151	-0.007	0.853	0.036	0.033	0	50.3	49.5	71.8	147	145	0	30	30
2015	7	5	8	36	52	0.082	0.026	0.853	0.033	0.03	0	50.3	48.6	72.7	148	143	0	31	30
2015	7	5	8	46	52	0.105	-0.023	0.856	0.036	0.033	0	50.3	49	71.8	147	144	0	30	30
2015	7	5	8	56	52	0.013	-0.112	0.853	0.033	0.03	0	50.3	49.5	71.8	147	145	0	30	30
2015	7	5	9	6	52	0.052	-0.121	0.853	0.036	0.033	0	51.6	49.9	71.8	151	146	0	31	30
2015	7	5	9	16	52	0.046	-0.102	0.856	0.039	0.039	0	51.2	49.5	73.5	149	145	0	30	30
2015	7	5	9	26	52	0.095	0.046	0.853	0.033	0.03	0	51.6	49.5	72.2	150	145	0	30	30
2015	7	5	9	36	52	0.128	0.052	0.856	0.033	0.03	0	49.9	49.5	72.2	147	145	0	31	30
2015	7	5	9	46	52	0.167	-0.013	0.856	0.033	0.03	0	49.9	50.3	71.8	148	146	0	32	29
2015	7	5	9	56	52	0.135	0.036	0.856	0.033	0.03	0	49.5	50.3	72.7	146	147	0	31	30
2015	7	5	10	6	52	0.098	0.059	0.853	0.033	0.03	0	51.2	50.3	72.7	149	147	0	30	30
2015	7	5	10	16	52	0.128	0.026	0.856	0.036	0.033	0	51.6	50.3	72.2	150	147	0	30	30
2015	7	5	10	26	52	0.151	0.013	0.856	0.036	0.033	0	51.2	51.2	71.8	149	148	0	30	29
2015	7	5	10	36	52	0.164	0.046	0.853	0.033	0.03	0	51.2	51.2	71.4	150	149	0	31	30
2015	7	5	10	46	52	0.253	0.118	0.853	0.033	0.03	0	50.7	51.2	71.8	149	149	0	31	30
2015	7	5	10	56	52	0.121	0.026	0.853	0.036	0.033	0	52	51.6	72.7	151	150	0	30	30
2015	7	5	11	6	52	0.141	-0.02	0.853	0.036	0.033	0	52.5	52	70.1	152	151	0	30	30
2015	7	5	11	16	52	0.22	0	0.853	0.033	0.03	0	52.9	52.5	71	153	152	0	30	30
2015	7	5	11	26	52	0.203	0.007	0.853	0.036	0.033	0	51.6	52.9	71.4	151	152	0	31	29
2015	7	5	11	36	52	0.118	0.046	0.853	0.033	0.03	0	52.5	53.3	70.1	152	154	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	5	11	46	52	0.187	-0.092	0.853	0.033	0.03	0	53.3	53.8	68.4	154	154	0	30	29
2015	7	5	11	56	52	0.112	0.046	0.85	0.039	0.036	0	53.8	54.2	68.8	155	156	0	30	30
2015	7	5	12	6	52	0.177	0.003	0.85	0.033	0.03	0	54.6	54.6	67.1	158	156	0	31	29
2015	7	5	12	16	52	0.21	0.131	0.85	0.033	0.03	0	55	54.6	67.9	159	157	0	31	30
2015	7	5	12	26	52	0.115	0.016	0.85	0.043	0.043	0	54.6	55.5	67.5	157	158	0	30	29
2015	7	5	12	36	52	0.187	0.066	0.85	0.033	0.03	0	56.3	55.9	67.5	161	159	0	30	29
2015	7	5	12	46	52	0.128	0.036	0.85	0.03	0.03	0	56.3	55.9	65.8	161	160	0	30	30
2015	7	5	12	56	52	0.18	0.062	0.85	0.033	0.03	0	56.3	56.3	64.9	161	160	0	30	29
2015	7	5	13	6	52	0.066	0.154	0.85	0.039	0.036	0	57.2	56.3	64.1	163	160	0	30	29
2015	7	5	13	16	52	0.144	0.049	0.85	0.036	0.033	0	57.6	55.9	65.4	164	160	0	30	30
2015	7	5	13	26	52	0.135	0.069	0.85	0.036	0.033	0	57.2	56.8	64.5	163	161	0	30	29
2015	7	5	13	36	52	0.112	0.056	0.85	0.033	0.03	0	53.3	52.9	67.1	154	153	0	30	30
2015	7	5	13	46	52	0.046	0.102	0.85	0.039	0.036	0	46.9	46.4	71.8	139	137	0	30	29
2015	7	5	13	56	52	0.036	0.095	0.85	0.033	0.03	0	47.7	46.4	72.7	140	137	0	29	29
2015	7	5	14	6	52	0.036	0.056	0.85	0.036	0.033	0	50.7	48.2	68.8	147	141	0	29	29
2015	7	5	14	16	52	0.052	0.013	0.846	0.036	0.033	0	50.3	48.6	66.2	147	142	0	30	29
2015	7	5	14	26	52	0.092	0.039	0.846	0.039	0.036	0	50.3	49.9	67.1	147	145	0	30	29
2015	7	5	14	36	52	0.131	0.046	0.85	0.039	0.036	0	50.7	49	68.8	149	143	0	31	29
2015	7	5	14	46	52	0.125	-0.03	0.85	0.039	0.036	0	49.9	49	69.7	146	143	0	30	29
2015	7	5	14	56	52	-0.03	0.157	0.85	0.039	0.036	0	49	49	70.5	144	143	0	30	29
2015	7	5	15	6	52	0	0.187	0.85	0.039	0.039	0	48.6	49.9	70.1	143	145	0	30	29
2015	7	5	15	16	52	-0.043	0.272	0.85	0.036	0.033	0	48.2	49.5	71.8	142	144	0	30	29
2015	7	5	15	26	52	0.007	0.299	0.85	0.033	0.03	0	48.2	48.6	71.8	142	142	0	30	29
2015	7	5	15	36	52	0.016	0.118	0.846	0.039	0.036	0	49.5	48.6	68.8	145	143	0	30	30
2015	7	5	15	46	52	0.039	0.121	0.846	0.036	0.033	0	49.9	49	67.9	146	143	0	30	29
2015	7	5	15	56	52	0.075	0.082	0.846	0.033	0.03	0	48.6	49.5	67.9	144	144	0	31	29
2015	7	5	16	6	52	-0.003	0.144	0.846	0.033	0.03	0	49.5	49.5	67.9	145	144	0	30	29
2015	7	5	16	16	52	0.043	0.217	0.85	0.033	0.03	0	47.3	49.5	71.4	140	144	0	30	29
2015	7	5	16	26	52	0.171	0.095	0.85	0.033	0.03	0	48.2	48.6	70.1	143	141	0	31	28
2015	7	5	16	36	52	0.154	0.039	0.85	0.036	0.033	0	50.7	50.3	68.8	148	146	0	30	29
2015	7	5	16	46	52	0.154	0.095	0.85	0.033	0.03	0	53.3	55	67.1	154	157	0	30	29
2015	7	5	16	56	52	0.141	0.102	0.85	0.039	0.036	0	55	53.8	66.2	158	154	0	30	29
2015	7	5	17	6	52	0.154	0.075	0.85	0.033	0.03	0	52.5	52	67.9	152	150	0	30	29
2015	7	5	17	16	52	0.069	0.052	0.85	0.036	0.033	0	53.8	53.3	66.7	155	153	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	5	17	26	52	0.151	0.056	0.85	0.036	0.033	0	53.8	55	68.4	155	157	0	30	29
2015	7	5	17	36	52	0.236	-0.007	0.85	0.033	0.03	0	52.5	53.8	67.9	153	154	0	31	29
2015	7	5	17	46	52	0.246	0.02	0.85	0.039	0.036	0	48.6	53.8	70.1	143	154	0	30	29
2015	7	5	17	56	52	0.112	-0.013	0.85	0.033	0.03	0	50.3	51.2	70.1	146	148	0	29	29
2015	7	5	18	6	52	0.125	-0.059	0.85	0.036	0.033	0	48.6	49.9	71	144	145	0	31	29
2015	7	5	18	16	52	0.092	0.03	0.846	0.036	0.033	0	48.2	49.9	71	142	145	0	30	29
2015	7	5	18	26	52	-0.033	0.033	0.846	0.03	0.03	0	47.7	51.6	69.7	141	149	0	30	29
2015	7	5	18	36	52	0.066	-0.01	0.846	0.036	0.033	0	46.9	48.2	71.4	139	141	0	30	29
2015	7	5	18	46	52	0.154	-0.092	0.846	0.033	0.03	0	46	46.4	71	137	137	0	30	29
2015	7	5	18	56	52	0.19	-0.079	0.846	0.036	0.033	0	46	46	71.4	137	136	0	30	29
2015	7	5	19	6	52	0.18	-0.013	0.846	0.039	0.036	0	47.3	46.9	70.1	140	138	0	30	29
2015	7	5	19	16	52	0.164	-0.023	0.846	0.033	0.03	0	46.4	47.3	71	138	139	0	30	29
2015	7	5	19	26	52	0.171	-0.046	0.846	0.036	0.033	0	48.6	48.6	69.7	143	142	0	30	29
2015	7	5	19	36	52	0.249	-0.089	0.846	0.039	0.039	0	49.5	48.6	68.8	145	143	0	30	30
2015	7	5	19	46	52	0.138	-0.033	0.846	0.039	0.039	0	49.9	49.5	67.9	146	144	0	30	29
2015	7	5	19	56	52	0.072	0.016	0.846	0.043	0.039	0	49.5	49	68.8	145	143	0	30	29
2015	7	5	20	6	52	0.148	-0.007	0.846	0.039	0.036	0	50.7	49.9	66.7	148	145	0	30	29
2015	7	5	20	16	52	0.157	-0.075	0.846	0.039	0.039	0	50.3	49.9	67.5	147	144	0	30	28
2015	7	5	20	26	52	0.112	-0.036	0.846	0.043	0.039	0	50.3	49	67.9	147	143	0	30	29
2015	7	5	20	36	52	0.171	0.079	0.846	0.039	0.036	0	49.5	48.6	68.8	145	142	0	30	29
2015	7	5	20	46	52	0.207	-0.026	0.846	0.036	0.033	0	49.9	48.2	67.9	146	141	0	30	29
2015	7	5	20	56	52	0.128	0.049	0.846	0.039	0.036	0	49.5	49	67.5	145	143	0	30	29
2015	7	5	21	6	52	0.089	0.059	0.846	0.036	0.033	0	49.9	48.2	68.8	146	141	0	30	29
2015	7	5	21	16	52	0.161	-0.003	0.846	0.036	0.033	0	48.6	47.3	69.7	143	139	0	30	29
2015	7	5	21	26	52	0.161	-0.01	0.85	0.033	0.03	0	48.2	46.4	70.1	142	137	0	30	29
2015	7	5	21	36	52	0.069	0.023	0.846	0.036	0.033	0	48.2	46.4	70.5	142	137	0	30	29
2015	7	5	21	46	52	0.112	-0.052	0.846	0.039	0.036	0	48.2	46.9	71	142	138	0	30	29
2015	7	5	21	56	52	0.089	-0.039	0.846	0.036	0.033	0	47.7	46.9	71	142	138	0	31	29
2015	7	5	22	6	52	0.105	0.082	0.846	0.033	0.03	0	47.3	46.9	70.5	140	138	0	30	29
2015	7	5	22	16	52	0.203	-0.02	0.846	0.033	0.03	0	47.7	46.4	69.7	141	137	0	30	29
2015	7	5	22	26	52	0.138	0.003	0.85	0.039	0.036	0	48.2	47.7	69.7	142	140	0	30	29
2015	7	5	22	36	52	0.115	0.01	0.85	0.033	0.03	0	48.2	46.4	69.2	142	137	0	30	29
2015	7	5	22	46	52	0.2	-0.049	0.85	0.039	0.036	0	47.7	46.4	70.5	141	137	0	30	29
2015	7	5	22	56	52	0.092	-0.026	0.846	0.033	0.033	0	48.2	47.3	70.5	142	139	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	5	23	6	52	0.082	0.016	0.846	0.039	0.039	0	46.9	45.6	71.4	139	135	0	30	29
2015	7	5	23	16	52	0.171	0.016	0.846	0.033	0.03	0	46	46.4	71	138	137	0	31	29
2015	7	5	23	26	52	0.128	0.079	0.846	0.033	0.03	0	46.4	45.2	71.4	139	135	0	31	30
2015	7	5	23	36	52	0.148	0	0.846	0.036	0.033	0	47.3	46.4	70.1	141	137	0	31	29
2015	7	5	23	46	52	0.177	-0.01	0.846	0.039	0.036	0	46.9	46	71.4	139	136	0	30	29
2015	7	5	23	56	52	0.164	-0.03	0.85	0.03	0.03	0	46.4	46	71.8	138	136	0	30	29
2015	7	6	0	6	52	0.112	-0.036	0.846	0.039	0.036	0	46.4	45.6	72.2	138	135	0	30	29
2015	7	6	0	16	52	0.177	-0.075	0.846	0.036	0.033	0	46.4	45.2	72.2	139	134	0	31	29
2015	7	6	0	26	52	0.184	-0.026	0.85	0.039	0.036	0	45.6	45.2	71.8	137	135	0	31	30
2015	7	6	0	36	52	0.171	0.026	0.846	0.036	0.033	0	46.9	46.4	71.8	139	137	0	30	29
2015	7	6	0	46	52	0.144	-0.059	0.85	0.036	0.033	0	47.3	46	71.8	140	137	0	30	30
2015	7	6	0	56	52	0.131	0.003	0.85	0.033	0.03	0	46	46.4	73.1	138	137	0	31	29
2015	7	6	1	6	52	0.128	-0.056	0.85	0.036	0.033	0	46	45.2	73.5	137	135	0	30	30
2015	7	6	1	16	52	0.121	-0.082	0.85	0.036	0.033	0	47.3	46.4	73.1	140	138	0	30	30
2015	7	6	1	26	52	0.138	-0.036	0.85	0.033	0.03	0	46	45.2	74	137	135	0	30	30
2015	7	6	1	36	52	0.108	0	0.85	0.036	0.033	0	46	45.6	72.7	137	136	0	30	30
2015	7	6	1	46	52	0.148	-0.049	0.85	0.033	0.03	0	46	45.2	74	138	135	0	31	30
2015	7	6	1	56	52	0.161	-0.036	0.85	0.039	0.039	0	45.6	45.6	74.4	137	135	0	31	29
2015	7	6	2	6	52	0.138	0.02	0.85	0.033	0.03	0	46.4	45.6	74	138	135	0	30	29
2015	7	6	2	16	52	0.125	-0.023	0.85	0.039	0.036	0	46	44.7	73.5	138	134	0	31	30
2015	7	6	2	26	52	0.098	-0.033	0.85	0.036	0.033	0	45.2	45.2	73.5	136	134	0	31	29
2015	7	6	2	36	52	0.138	-0.072	0.853	0.033	0.03	0	45.6	44.3	74	136	133	0	30	30
2015	7	6	2	46	52	0.18	-0.079	0.853	0.033	0.03	0	45.6	44.7	74.4	136	133	0	30	29
2015	7	6	2	56	52	0.194	-0.016	0.853	0.039	0.036	0	46.4	44.3	74.4	138	133	0	30	30
2015	7	6	3	6	52	0.115	-0.033	0.853	0.039	0.039	0	45.2	44.7	75.3	136	132	0	31	28
2015	7	6	3	16	52	0.105	-0.049	0.853	0.049	0.049	0	46	44.7	74.4	138	133	0	31	29
2015	7	6	3	26	52	0.135	0	0.853	0.033	0.03	0	45.6	44.3	74.8	136	133	0	30	30
2015	7	6	3	36	52	0.144	-0.062	0.853	0.036	0.033	0	45.2	43.9	74.8	136	132	0	31	30
2015	7	6	3	46	52	0.125	-0.056	0.853	0.039	0.036	0	44.7	44.3	75.3	134	133	0	30	30
2015	7	6	3	56	52	0.128	-0.075	0.853	0.039	0.036	0	44.7	43.4	74.8	134	131	0	30	30
2015	7	6	4	6	52	0.131	-0.033	0.853	0.039	0.039	0	43.4	42.1	75.3	133	128	0	32	30
2015	7	6	4	16	52	0.19	0.023	0.853	0.036	0.033	0	43.4	44.7	75.3	132	133	0	31	29
2015	7	6	4	26	52	0.164	-0.056	0.853	0.033	0.03	0	43.9	43.4	75.3	133	130	0	31	29
2015	7	6	4	36	52	0.121	-0.033	0.853	0.036	0.033	0	44.7	43.9	74.8	135	131	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	6	4	46	52	0.115	0.043	0.853	0.036	0.033	0	43.9	43.9	74	133	132	0	31	30
2015	7	6	4	56	52	0.112	-0.056	0.853	0.039	0.039	0	43.9	43.4	75.7	133	131	0	31	30
2015	7	6	5	6	52	0.115	0	0.853	0.033	0.033	0	44.7	43.4	75.3	135	131	0	31	30
2015	7	6	5	16	52	0.253	-0.013	0.853	0.039	0.036	0	46	45.2	74	138	135	0	31	30
2015	7	6	5	26	52	0.18	-0.082	0.853	0.033	0.03	0	44.3	43.9	74.8	134	132	0	31	30
2015	7	6	5	36	52	0.138	0.003	0.853	0.033	0.03	0	44.7	43.4	75.7	134	130	0	30	29
2015	7	6	5	46	52	0.089	-0.072	0.853	0.036	0.033	0	47.3	45.6	71.8	140	136	0	30	30
2015	7	6	5	56	52	0.167	-0.039	0.853	0.039	0.036	0	47.3	46	71.8	141	137	0	31	30
2015	7	6	6	6	52	0.164	-0.043	0.853	0.043	0.039	0	45.2	44.7	73.5	136	133	0	31	29
2015	7	6	6	16	52	0.092	0	0.853	0.033	0.03	0	46.4	45.2	72.7	139	135	0	31	30
2015	7	6	6	26	52	0.039	-0.02	0.853	0.039	0.036	0	46	44.7	73.1	138	134	0	31	30
2015	7	6	6	36	52	0.144	-0.046	0.853	0.039	0.036	0	46	44.3	73.5	137	133	0	30	30
2015	7	6	6	46	52	0.164	-0.003	0.853	0.039	0.036	0	45.2	43	74.8	135	130	0	30	30
2015	7	6	6	56	52	0.187	-0.121	0.853	0.039	0.039	0	46.4	44.7	73.5	138	134	0	30	30
2015	7	6	7	6	52	0.157	0.033	0.853	0.039	0.036	0	45.6	44.3	74.4	136	133	0	30	30
2015	7	6	7	16	52	0.164	0.033	0.856	0.036	0.033	0	45.6	43.4	74.4	136	131	0	30	30
2015	7	6	7	26	52	0.108	-0.056	0.856	0.039	0.039	0	46.9	44.7	73.5	139	134	0	30	30
2015	7	6	7	36	52	0.135	-0.072	0.856	0.043	0.039	0	45.2	43.9	74.8	135	132	0	30	30
2015	7	6	7	46	52	0.115	-0.026	0.856	0.033	0.03	0	44.7	43.9	75.3	135	132	0	31	30
2015	7	6	7	56	52	0.177	0.016	0.856	0.033	0.03	0	47.3	46.4	73.1	140	138	0	30	30
2015	7	6	8	6	52	0.203	0.016	0.856	0.033	0.03	0	48.6	46.9	72.7	144	139	0	31	30
2015	7	6	8	16	52	0.174	0.052	0.856	0.036	0.033	0	49.9	48.2	72.7	146	142	0	30	30
2015	7	6	8	26	52	0.217	0.003	0.856	0.033	0.03	0	49.9	48.6	71.8	147	143	0	31	30
2015	7	6	8	36	52	0.2	-0.066	0.856	0.036	0.033	0	49.9	49.5	71.4	147	145	0	31	30
2015	7	6	8	46	52	0.184	-0.02	0.856	0.033	0.03	0	49	48.2	72.2	145	142	0	31	30
2015	7	6	8	56	52	0.164	0.003	0.856	0.033	0.03	0	49.9	48.6	73.5	146	143	0	30	30
2015	7	6	9	6	52	0.161	0.079	0.856	0.033	0.033	0	50.3	49.9	73.1	148	146	0	31	30
2015	7	6	9	16	52	0.174	-0.036	0.856	0.036	0.033	0	50.7	50.3	71.4	149	146	0	31	29
2015	7	6	9	26	52	0.102	-0.02	0.856	0.033	0.03	0	50.3	50.3	71.4	148	147	0	31	30
2015	7	6	9	36	52	0.164	-0.052	0.856	0.033	0.03	0	51.2	50.3	71.8	149	146	0	30	29
2015	7	6	9	46	52	0.148	0.023	0.856	0.036	0.033	0	49.9	50.3	72.7	147	146	0	31	29
2015	7	6	9	56	52	0.164	0.013	0.856	0.033	0.03	0	52.5	51.2	71	153	149	0	31	30
2015	7	6	10	6	52	0.167	0.092	0.863	0.039	0.039	0	59.3	57.2	66.7	169	162	0	31	29
2015	7	6	10	16	52	0.19	0.016	0.86	0.036	0.033	0	61.5	56.3	65.8	173	160	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	6	10	26	52	0.144	0.115	0.86	0.039	0.039	0	59.8	57.2	66.2	170	162	0	31	29
2015	7	6	10	36	52	0.092	0.059	0.856	0.043	0.039	0	58.9	58.5	64.9	167	165	0	30	29
2015	7	6	10	46	52	0.164	0.092	0.856	0.036	0.033	0	58.9	58.5	65.8	167	166	0	30	30
2015	7	6	10	56	52	0.154	0.036	0.856	0.036	0.033	0	58.5	58	66.7	166	166	0	30	31
2015	7	6	11	6	52	0.177	0.049	0.856	0.033	0.03	0	60.6	59.3	65.4	171	168	0	30	30
2015	7	6	11	16	52	0.203	0.066	0.856	0.039	0.036	0	59.3	59.3	64.9	169	168	0	31	30
2015	7	6	11	26	52	0.115	0.089	0.856	0.033	0.03	0	60.2	60.2	64.5	170	169	0	30	29
2015	7	6	11	36	52	0.197	0.085	0.856	0.033	0.03	0	60.6	59.8	64.1	171	169	0	30	30
2015	7	6	11	46	52	0.128	0.066	0.856	0.039	0.036	0	60.6	60.2	64.1	171	170	0	30	30
2015	7	6	11	56	52	0.184	0.059	0.856	0.039	0.036	0	61.5	60.6	63.6	174	170	0	31	29
2015	7	6	12	6	52	0.213	0.036	0.856	0.033	0.033	0	60.6	60.2	63.2	172	169	0	31	29
2015	7	6	12	16	52	0.128	0.03	0.856	0.033	0.03	0	61.1	59.8	63.6	173	169	0	31	30
2015	7	6	12	26	52	0.167	0.121	0.856	0.036	0.033	0	61.9	60.2	61.9	174	170	0	30	30
2015	7	6	12	36	52	0.174	0.072	0.856	0.036	0.033	0	62.8	60.6	63.6	177	170	0	31	29
2015	7	6	12	46	52	0.154	-0.01	0.856	0.033	0.03	0	61.5	60.6	63.2	174	171	0	31	30
2015	7	6	12	56	52	0.167	0.072	0.856	0.036	0.033	0	62.4	60.6	64.5	175	170	0	30	29
2015	7	6	13	6	52	0.138	0.026	0.856	0.033	0.03	0	62.4	60.6	63.2	175	170	0	30	29
2015	7	6	13	16	52	0.194	0.151	0.856	0.036	0.033	0	62.4	61.1	64.1	176	171	0	31	29
2015	7	6	13	26	52	0.151	0.069	0.856	0.033	0.03	0	63.2	61.1	61.5	177	171	0	30	29
2015	7	6	13	36	52	0.19	0.095	0.856	0.039	0.039	0	64.1	61.5	59.8	179	173	0	30	30
2015	7	6	13	46	52	0.131	0.131	0.856	0.039	0.036	0	64.1	61.5	61.5	179	172	0	30	29
2015	7	6	13	56	52	0.148	-0.007	0.856	0.039	0.036	0	64.1	61.1	60.6	179	171	0	30	29
2015	7	6	14	6	52	0.164	0.062	0.86	0.039	0.039	0	63.6	61.5	61.1	178	172	0	30	29
2015	7	6	14	16	52	0.164	0.095	0.856	0.039	0.039	0	64.1	61.5	60.6	179	172	0	30	29
2015	7	6	14	26	52	0.148	0.046	0.856	0.039	0.039	0	64.1	60.6	61.5	179	170	0	30	29
2015	7	6	14	36	52	0.2	0.066	0.856	0.036	0.033	0	64.5	62.4	60.6	180	173	0	30	28
2015	7	6	14	46	52	0.154	0.121	0.856	0.039	0.036	0	64.1	61.1	61.9	178	170	0	29	28
2015	7	6	14	56	52	0.184	0.072	0.856	0.036	0.033	0	61.5	58.9	64.1	173	166	0	30	29
2015	7	6	15	6	52	0.171	0.056	0.856	0.039	0.036	0	55.5	55	68.4	160	157	0	31	29
2015	7	6	15	16	52	0.125	0.007	0.856	0.036	0.033	0	55.5	52.9	70.5	158	152	0	29	29
2015	7	6	15	26	52	0.118	-0.023	0.856	0.039	0.036	0	56.8	52.9	69.7	162	152	0	30	29
2015	7	6	15	36	52	0.194	0.033	0.856	0.036	0.033	0	56.3	52.9	68.8	161	152	0	30	29
2015	7	6	15	46	52	0.187	-0.007	0.856	0.039	0.036	0	57.6	52.5	69.7	164	151	0	30	29
2015	7	6	15	56	52	0.105	0.036	0.86	0.039	0.039	0	58.9	53.8	68.4	167	155	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	6	16	6	52	0.217	0.082	0.856	0.036	0.033	0	64.5	61.1	59.3	179	171	0	29	29
2015	7	6	16	16	52	0.131	0.102	0.856	0.043	0.039	0	60.6	57.6	65.4	171	163	0	30	29
2015	7	6	16	26	52	0.223	0.121	0.856	0.033	0.03	0	64.1	60.2	60.6	179	169	0	30	29
2015	7	6	16	36	52	0.19	0.121	0.856	0.036	0.033	0	62.4	59.3	62.8	175	167	0	30	29
2015	7	6	16	46	52	0.21	0.095	0.856	0.039	0.036	0	61.1	58	64.5	172	164	0	30	29
2015	7	6	16	56	52	0.174	0.082	0.856	0.039	0.039	0	58.9	56.8	64.9	168	160	0	31	28
2015	7	6	17	6	52	0.141	-0.03	0.856	0.039	0.036	0	54.6	52.5	68.4	157	151	0	30	29
2015	7	6	17	16	52	0.164	-0.059	0.856	0.036	0.033	0	52	49.9	71.4	151	145	0	30	29
2015	7	6	17	26	52	0.141	0	0.853	0.039	0.039	0	50.3	48.2	70.1	147	141	0	30	29
2015	7	6	17	36	52	0.105	0.02	0.853	0.039	0.036	0	49	48.2	70.1	144	141	0	30	29
2015	7	6	17	46	52	0.177	-0.01	0.853	0.036	0.033	0	49	47.3	69.7	144	139	0	30	29
2015	7	6	17	56	52	0.059	0.026	0.853	0.046	0.043	0	47.3	46	71.8	140	136	0	30	29
2015	7	6	18	6	52	0.177	0.003	0.853	0.039	0.036	0	46.9	45.6	71.8	139	136	0	30	30
2015	7	6	18	16	52	0.151	-0.033	0.853	0.033	0.03	0	48.6	46.9	70.5	143	138	0	30	29
2015	7	6	18	26	52	0.141	0	0.856	0.039	0.036	0	49	47.7	70.1	144	140	0	30	29
2015	7	6	18	36	52	0.131	0.007	0.853	0.036	0.033	0	46.4	45.6	72.2	139	135	0	31	29
2015	7	6	18	46	52	0.072	0.072	0.853	0.043	0.039	0	49.5	48.2	69.7	145	140	0	30	28
2015	7	6	18	56	52	0.075	-0.03	0.853	0.039	0.036	0	49.5	47.7	69.7	145	140	0	30	29
2015	7	6	19	6	52	0.161	0.003	0.853	0.036	0.033	0	46.9	45.2	71.8	139	134	0	30	29
2015	7	6	19	16	52	0.23	-0.039	0.853	0.033	0.03	0	49	46.9	70.1	144	138	0	30	29
2015	7	6	19	26	52	0.197	-0.075	0.853	0.039	0.039	0	49.9	47.7	70.1	145	140	0	29	29
2015	7	6	19	36	52	0.128	-0.01	0.853	0.036	0.033	0	49	47.3	69.7	144	139	0	30	29
2015	7	6	19	46	52	0.164	-0.052	0.853	0.039	0.036	0	48.6	47.7	67.9	143	140	0	30	29
2015	7	6	19	56	52	0.102	-0.02	0.853	0.036	0.033	0	50.3	48.2	66.2	147	141	0	30	29
2015	7	6	20	6	52	0.167	0.003	0.853	0.033	0.03	0	52	50.3	64.1	151	146	0	30	29
2015	7	6	20	16	52	0.161	0.049	0.856	0.033	0.03	0	55.9	54.2	63.2	160	155	0	30	29
2015	7	6	20	26	52	0.151	-0.056	0.853	0.043	0.043	0	51.2	49	68.8	148	143	0	29	29
2015	7	6	20	36	52	0.148	-0.039	0.853	0.033	0.03	0	50.3	48.6	68.8	146	141	0	29	28
2015	7	6	20	46	52	0.154	-0.039	0.853	0.036	0.033	0	50.3	48.6	68.8	147	142	0	30	29
2015	7	6	20	56	52	0.144	0.039	0.853	0.039	0.039	0	49.9	49.5	67.9	146	144	0	30	29
2015	7	6	21	6	52	0.154	-0.013	0.853	0.043	0.043	0	49.5	48.6	69.7	144	142	0	29	29
2015	7	6	21	16	52	0.092	-0.013	0.853	0.039	0.039	0	50.7	48.6	67.5	148	143	0	30	30
2015	7	6	21	26	52	0.177	0.016	0.853	0.039	0.036	0	50.3	48.6	67.9	147	142	0	30	29
2015	7	6	21	36	52	0.098	0.036	0.853	0.033	0.03	0	52	50.3	67.1	151	146	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	6	21	46	52	0.207	0.016	0.853	0.039	0.036	0	52.5	50.7	67.1	152	147	0	30	29
2015	7	6	21	56	52	0.148	-0.036	0.853	0.043	0.039	0	51.2	48.6	68.4	149	143	0	30	30
2015	7	6	22	6	52	0.157	-0.007	0.853	0.039	0.039	0	50.3	48.6	69.2	147	142	0	30	29
2015	7	6	22	16	52	0.125	-0.036	0.853	0.043	0.043	0	51.6	50.3	67.5	150	146	0	30	29
2015	7	6	22	26	52	0.194	0	0.853	0.039	0.039	0	53.3	51.6	66.2	154	150	0	30	30
2015	7	6	22	36	52	0.161	0.016	0.853	0.033	0.03	0	51.2	50.3	67.5	150	146	0	31	29
2015	7	6	22	46	52	0.2	-0.043	0.853	0.036	0.033	0	53.3	52	65.8	154	149	0	30	28
2015	7	6	22	56	52	0.19	-0.059	0.853	0.039	0.039	0	51.2	49.9	67.1	149	145	0	30	29
2015	7	6	23	6	52	0.187	-0.052	0.853	0.039	0.036	0	49.9	48.2	70.5	146	142	0	30	30
2015	7	6	23	16	52	0.164	-0.095	0.856	0.043	0.039	0	48.6	48.2	71.4	143	141	0	30	29
2015	7	6	23	26	52	0.112	-0.023	0.856	0.039	0.039	0	48.6	47.3	71.4	143	139	0	30	29
2015	7	6	23	36	52	0.22	0.007	0.853	0.039	0.036	0	48.6	47.7	71	143	140	0	30	29
2015	7	6	23	46	52	0.164	-0.085	0.856	0.033	0.03	0	47.7	46.4	72.2	141	137	0	30	29
2015	7	6	23	56	52	0.184	-0.043	0.856	0.036	0.033	0	47.3	46.4	72.2	140	137	0	30	29
2015	7	7	0	6	52	0.118	-0.039	0.856	0.039	0.036	0	47.7	47.7	72.2	141	140	0	30	29
2015	7	7	0	16	52	0.128	0.003	0.856	0.036	0.033	0	49.9	48.2	72.7	146	141	0	30	29
2015	7	7	0	26	52	0.138	0	0.856	0.046	0.043	0	48.2	47.7	72.7	142	140	0	30	29
2015	7	7	0	36	52	0.151	0.003	0.856	0.039	0.036	0	46	46	74.4	138	136	0	31	29
2015	7	7	0	46	52	0.121	-0.066	0.856	0.033	0.03	0	45.6	45.6	75.3	137	135	0	31	29
2015	7	7	0	56	52	0.177	0.003	0.856	0.033	0.03	0	45.6	45.2	75.7	136	135	0	30	30
2015	7	7	1	6	52	0.171	0.01	0.856	0.036	0.033	0	44.7	45.6	74.8	135	135	0	31	29
2015	7	7	1	16	52	0.128	-0.095	0.856	0.039	0.039	0	45.2	45.2	75.7	136	134	0	31	29
2015	7	7	1	26	52	0.148	-0.03	0.856	0.033	0.03	0	46	46	74.8	138	136	0	31	29
2015	7	7	1	36	52	0.19	-0.125	0.856	0.036	0.033	0	47.3	46.4	75.3	140	137	0	30	29
2015	7	7	1	46	52	0.151	0	0.856	0.039	0.036	0	48.2	47.7	73.5	142	140	0	30	29
2015	7	7	1	56	52	0.075	0	0.856	0.033	0.03	0	44.7	44.7	74.8	135	134	0	31	30
2015	7	7	2	6	52	0.148	-0.095	0.856	0.033	0.03	0	45.2	45.6	74.8	136	136	0	31	30
2015	7	7	2	16	52	0.148	-0.026	0.856	0.046	0.043	0	46	44.7	75.7	137	134	0	30	30
2015	7	7	2	26	52	0.197	-0.046	0.856	0.039	0.039	0	46	45.2	75.3	137	134	0	30	29
2015	7	7	2	36	52	0.171	-0.066	0.856	0.033	0.03	0	45.2	45.2	75.7	135	135	0	30	30
2015	7	7	2	46	52	0.203	-0.007	0.856	0.039	0.036	0	46.9	45.6	74.4	139	136	0	30	30
2015	7	7	2	56	52	0.203	-0.062	0.856	0.039	0.036	0	45.6	43.9	75.3	136	132	0	30	30
2015	7	7	3	6	52	0.128	-0.095	0.856	0.033	0.03	0	46.4	46	74.4	138	135	0	30	28
2015	7	7	3	16	52	0.138	0.02	0.856	0.033	0.03	0	47.7	46	72.7	141	137	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	7	3	26	52	0.148	-0.075	0.856	0.039	0.036	0	48.2	47.3	71.4	142	139	0	30	29
2015	7	7	3	36	52	0.161	-0.026	0.856	0.039	0.036	0	47.3	46.9	72.2	140	138	0	30	29
2015	7	7	3	46	52	0.187	-0.043	0.853	0.039	0.039	0	48.2	47.3	72.2	142	140	0	30	30
2015	7	7	3	56	52	0.223	-0.013	0.853	0.039	0.036	0	45.2	45.2	73.5	136	135	0	31	30
2015	7	7	4	6	52	0.167	-0.023	0.853	0.033	0.03	0	47.7	46.9	72.7	141	138	0	30	29
2015	7	7	4	16	52	0.125	-0.013	0.853	0.039	0.039	0	48.2	46.9	71.8	142	139	0	30	30
2015	7	7	4	26	52	0.102	-0.013	0.853	0.036	0.033	0	47.3	46.4	71.4	141	138	0	31	30
2015	7	7	4	36	52	0.18	0.039	0.853	0.039	0.036	0	48.2	46.4	71.8	142	138	0	30	30
2015	7	7	4	46	52	0.108	-0.066	0.853	0.036	0.033	0	48.6	47.3	71	143	139	0	30	29
2015	7	7	4	56	52	0.095	0.069	0.853	0.039	0.036	0	49	47.3	71.4	144	139	0	30	29
2015	7	7	5	6	52	0.072	-0.125	0.856	0.036	0.033	0	46.4	45.2	74	138	135	0	30	30
2015	7	7	5	16	52	0.095	-0.046	0.856	0.036	0.033	0	47.7	46	72.2	142	137	0	31	30
2015	7	7	5	26	52	0.138	0.02	0.856	0.033	0.03	0	45.2	43.9	75.3	135	132	0	30	30
2015	7	7	5	36	52	0.151	0	0.853	0.036	0.033	0	46.4	45.2	74	138	134	0	30	29
2015	7	7	5	46	52	0.121	-0.056	0.853	0.039	0.036	0	45.6	44.7	74.8	136	134	0	30	30
2015	7	7	5	56	52	0.22	-0.056	0.853	0.039	0.036	0	45.2	44.3	74.8	135	133	0	30	30
2015	7	7	6	6	52	0.18	-0.085	0.853	0.036	0.033	0	45.6	43.9	74.8	137	132	0	31	30
2015	7	7	6	16	52	0.115	-0.075	0.853	0.039	0.039	0	44.7	43.4	75.7	135	131	0	31	30
2015	7	7	6	26	52	0.144	-0.033	0.853	0.036	0.033	0	45.2	43.9	74.8	135	131	0	30	29
2015	7	7	6	36	52	0.141	-0.023	0.853	0.043	0.043	0	44.7	43.4	75.3	134	130	0	30	29
2015	7	7	6	46	52	0.184	0.046	0.853	0.039	0.036	0	45.6	44.7	74.8	136	134	0	30	30
2015	7	7	6	56	52	0.157	-0.023	0.853	0.036	0.033	0	45.6	44.3	74.8	137	133	0	31	30
2015	7	7	7	6	52	0.125	-0.039	0.856	0.039	0.036	0	46	44.7	74.8	137	133	0	30	29
2015	7	7	7	16	52	0.217	-0.016	0.856	0.039	0.036	0	44.3	43.9	75.3	134	131	0	31	29
2015	7	7	7	26	52	0.18	0.016	0.856	0.033	0.03	0	44.3	43	76.1	134	130	0	31	30
2015	7	7	7	36	52	0.171	-0.056	0.856	0.039	0.036	0	45.6	44.3	75.3	137	132	0	31	29
2015	7	7	7	46	52	0.164	0.046	0.856	0.039	0.039	0	45.6	43.9	76.1	136	132	0	30	30
2015	7	7	7	56	52	0.128	0.013	0.856	0.039	0.036	0	46.9	45.6	74.4	140	136	0	31	30
2015	7	7	8	6	52	0.115	-0.033	0.856	0.039	0.036	0	47.3	46.9	75.3	140	138	0	30	29
2015	7	7	8	16	52	0.141	-0.075	0.856	0.039	0.036	0	48.2	47.3	73.1	142	140	0	30	30
2015	7	7	8	26	52	0.151	-0.007	0.853	0.039	0.036	0	50.7	49.5	72.2	149	144	0	31	29
2015	7	7	8	36	52	0.174	0.013	0.856	0.033	0.03	0	50.7	49.5	73.5	148	145	0	30	30
2015	7	7	8	46	52	0.197	0.03	0.856	0.036	0.033	0	50.7	49.9	72.7	148	146	0	30	30
2015	7	7	8	56	52	0.148	0.052	0.856	0.033	0.03	0	51.2	49.9	73.1	149	145	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	7	9	6	52	0.121	0.043	0.856	0.036	0.033	0	50.3	49.9	72.2	147	145	0	30	29
2015	7	7	9	16	52	0.177	-0.016	0.856	0.033	0.03	0	50.7	49	72.2	149	144	0	31	30
2015	7	7	9	26	52	0.213	0.023	0.853	0.033	0.03	0	50.7	49	72.7	149	143	0	31	29
2015	7	7	9	36	52	0.148	0.016	0.856	0.039	0.036	0	50.3	48.2	72.2	147	142	0	30	30
2015	7	7	9	46	52	0.085	0.013	0.853	0.039	0.036	0	49.9	48.6	72.7	147	142	0	31	29
2015	7	7	9	56	52	0.138	0.01	0.856	0.033	0.03	0	49.5	48.2	73.5	145	141	0	30	29
2015	7	7	10	6	52	0.121	-0.056	0.853	0.039	0.036	0	49.9	48.2	72.7	146	142	0	30	30
2015	7	7	10	16	52	0.115	-0.02	0.853	0.033	0.03	0	51.2	49.5	71	150	144	0	31	29
2015	7	7	10	26	52	0.167	-0.036	0.853	0.033	0.03	0	50.3	49.5	71.4	147	145	0	30	30
2015	7	7	10	36	52	0.115	0.066	0.853	0.033	0.03	0	49.9	50.7	70.5	147	147	0	31	29
2015	7	7	10	46	52	0.144	0.066	0.853	0.036	0.033	0	52.5	51.2	70.1	153	149	0	31	30
2015	7	7	10	56	52	0.131	0.026	0.85	0.036	0.033	0	51.6	52.5	71	151	151	0	31	29
2015	7	7	11	6	52	0.118	0.036	0.85	0.036	0.033	0	52.5	52.9	68.8	153	152	0	31	29
2015	7	7	11	16	52	0.128	0.079	0.85	0.036	0.033	0	53.3	53.8	68.8	154	154	0	30	29
2015	7	7	11	26	52	0.075	0.026	0.85	0.033	0.03	0	54.2	54.6	68.4	156	156	0	30	29
2015	7	7	11	36	52	0.108	0.079	0.85	0.036	0.033	0	54.2	54.2	68.4	156	155	0	30	29
2015	7	7	11	46	52	0.151	0.043	0.85	0.039	0.039	0	55.5	55	66.7	159	157	0	30	29
2015	7	7	11	56	52	0.118	0.023	0.846	0.033	0.03	0	55.9	55.9	65.4	160	159	0	30	29
2015	7	7	12	6	52	0.154	0.066	0.846	0.036	0.033	0	55.9	55.9	64.9	161	159	0	31	29
2015	7	7	12	16	52	0.125	0.052	0.846	0.039	0.036	0	57.2	56.3	64.5	163	161	0	30	30
2015	7	7	12	26	52	0.187	0.007	0.846	0.033	0.03	0	57.2	56.8	62.8	163	161	0	30	29
2015	7	7	12	36	52	0.089	0.007	0.846	0.036	0.033	0	58	56.3	62.8	165	161	0	30	30
2015	7	7	12	46	52	0.177	0.02	0.85	0.039	0.036	0	59.3	57.2	62.4	168	162	0	30	29
2015	7	7	12	56	52	0.138	0.092	0.85	0.036	0.033	0	58.9	58.5	62.4	167	165	0	30	29
2015	7	7	13	6	52	0.079	0.157	0.85	0.03	0.026	0	59.3	58.9	63.6	168	165	0	30	28
2015	7	7	13	16	52	0.141	0.056	0.85	0.036	0.033	0	59.8	58.5	62.4	169	166	0	30	30
2015	7	7	13	26	52	0.164	0.079	0.853	0.033	0.03	0	60.2	58.5	64.1	170	165	0	30	29
2015	7	7	13	36	52	0.154	0.075	0.856	0.033	0.03	0	60.6	58.9	62.4	171	166	0	30	29
2015	7	7	13	46	52	0.135	0.056	0.856	0.039	0.039	0	60.6	58.5	62.4	171	165	0	30	29
2015	7	7	13	56	52	0.148	0.069	0.856	0.033	0.03	0	60.6	58.9	61.9	171	167	0	30	30
2015	7	7	14	6	52	0.19	0.115	0.856	0.036	0.033	0	61.1	58.5	60.2	172	166	0	30	30
2015	7	7	14	16	52	0.167	0.072	0.86	0.036	0.033	0	61.9	59.3	61.1	174	167	0	30	29
2015	7	7	14	26	52	0.207	0.112	0.86	0.036	0.033	0	61.1	59.3	61.1	172	167	0	30	29
2015	7	7	14	36	52	0.135	0.108	0.86	0.039	0.039	0	61.9	59.8	61.1	173	168	0	29	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	7	14	46	52	0.154	0.085	0.86	0.036	0.033	0	61.9	59.3	62.4	174	167	0	30	29
2015	7	7	14	56	52	0.157	0.167	0.86	0.039	0.036	0	61.1	58.9	60.6	172	166	0	30	29
2015	7	7	15	6	52	0.194	0.098	0.863	0.039	0.039	0	61.5	58.5	61.9	173	166	0	30	30
2015	7	7	15	16	52	0.246	0.056	0.863	0.039	0.039	0	61.5	58	63.6	173	165	0	30	30
2015	7	7	15	26	52	0.23	0.115	0.863	0.039	0.036	0	61.9	58.9	62.4	173	166	0	29	29
2015	7	7	15	36	52	0.197	0.046	0.863	0.033	0.03	0	60.6	58.5	62.8	171	165	0	30	29
2015	7	7	15	46	52	0.21	0.066	0.863	0.039	0.039	0	60.2	58	61.9	170	164	0	30	29
2015	7	7	15	56	52	0.197	0.059	0.863	0.033	0.03	0	59.8	58	63.2	169	164	0	30	29
2015	7	7	16	6	52	0.213	0.135	0.866	0.036	0.033	0	60.2	57.2	62.8	170	162	0	30	29
2015	7	7	16	16	52	0.223	0.049	0.866	0.036	0.033	0	59.8	57.6	64.9	169	162	0	30	28
2015	7	7	16	26	52	0.171	0.016	0.866	0.039	0.039	0	59.3	56.8	64.1	168	161	0	30	29
2015	7	7	16	36	52	0.128	0.066	0.866	0.036	0.033	0	58	56.3	62.8	165	159	0	30	28
2015	7	7	16	46	52	0.19	0.098	0.866	0.039	0.036	0	58	55.5	64.1	165	158	0	30	29
2015	7	7	16	56	52	0.135	-0.016	0.869	0.039	0.039	0	57.2	54.6	62.8	163	156	0	30	29
2015	7	7	17	6	52	0.246	0.138	0.869	0.046	0.043	0	57.6	54.2	65.4	163	155	0	29	29
2015	7	7	17	16	52	0.19	0.039	0.869	0.039	0.036	0	55	53.3	66.7	158	153	0	30	29
2015	7	7	17	26	52	0.174	0.072	0.869	0.036	0.033	0	55.9	53.8	64.9	161	154	0	31	29
2015	7	7	17	36	52	0.135	0.01	0.869	0.033	0.03	0	52	51.6	67.1	151	148	0	30	28
2015	7	7	17	46	52	0.18	-0.007	0.869	0.036	0.033	0	49.9	49.5	67.5	146	144	0	30	29
2015	7	7	17	56	52	0.148	-0.013	0.869	0.036	0.033	0	49.9	48.6	68.4	146	142	0	30	29
2015	7	7	18	6	52	0.217	0.049	0.873	0.039	0.036	0	49.5	47.3	68.4	145	139	0	30	29
2015	7	7	18	16	52	0.21	-0.013	0.873	0.039	0.039	0	50.7	49	67.5	148	143	0	30	29
2015	7	7	18	26	52	0.246	-0.056	0.873	0.039	0.036	0	49	46.9	69.2	143	138	0	29	29
2015	7	7	18	36	52	0.164	0.079	0.873	0.039	0.036	0	52	50.3	64.5	151	146	0	30	29
2015	7	7	18	46	52	0.144	0.059	0.869	0.049	0.049	0	53.8	52	58	154	149	0	29	28
2015	7	7	18	56	52	0.213	-0.013	0.873	0.039	0.039	0	55.5	53.8	58.5	158	153	0	29	28
2015	7	7	19	6	52	0.154	0.039	0.873	0.039	0.039	0	53.8	52.5	61.5	155	151	0	30	29
2015	7	7	19	16	52	0.21	-0.066	0.876	0.043	0.039	0	53.3	52	62.8	154	150	0	30	29
2015	7	7	19	26	52	0.187	0	0.879	0.039	0.039	0	55	52.9	60.2	158	151	0	30	28
2015	7	7	19	36	52	0.157	0.007	0.883	0.039	0.036	0	52.9	50.7	64.9	152	147	0	29	29
2015	7	7	19	46	52	0.171	-0.03	0.879	0.039	0.039	0	54.6	52.9	60.6	157	152	0	30	29
2015	7	7	19	56	52	0.171	-0.046	0.883	0.036	0.033	0	53.3	51.6	62.4	154	149	0	30	29
2015	7	7	20	6	52	0.174	0	0.886	0.039	0.039	0	53.8	51.6	62.8	155	149	0	30	29
2015	7	7	20	16	52	0.118	-0.108	0.886	0.043	0.039	0	55.5	53.3	61.9	159	153	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	7	20	26	52	0.154	0.016	0.886	0.046	0.043	0	53.3	52	64.5	154	150	0	30	29
2015	7	7	20	36	52	0.105	-0.033	0.889	0.039	0.039	0	52.5	51.2	64.9	152	148	0	30	29
2015	7	7	20	46	52	0.207	-0.043	0.889	0.039	0.039	0	52.9	50.7	64.9	153	147	0	30	29
2015	7	7	20	56	52	0.217	-0.003	0.889	0.039	0.036	0	57.2	55.5	60.2	163	158	0	30	29
2015	7	7	21	6	52	0.128	-0.079	0.889	0.036	0.033	0	55	52.5	61.9	158	152	0	30	30
2015	7	7	21	16	52	0.249	0.016	0.889	0.039	0.036	0	53.3	51.2	66.7	153	148	0	29	29
2015	7	7	21	26	52	0.213	0.016	0.892	0.036	0.033	0	52.9	51.2	66.7	153	148	0	30	29
2015	7	7	21	36	52	0.217	-0.039	0.892	0.039	0.039	0	51.6	50.3	67.1	150	146	0	30	29
2015	7	7	21	46	52	0.249	-0.043	0.892	0.039	0.039	0	55.5	54.2	62.8	159	155	0	30	29
2015	7	7	21	56	52	0.207	0.03	0.892	0.036	0.033	0	51.6	49.9	67.5	150	145	0	30	29
2015	7	7	22	6	52	0.226	0.062	0.892	0.033	0.03	0	49.5	47.7	67.5	145	141	0	30	30
2015	7	7	22	16	52	0.226	-0.02	0.892	0.033	0.03	0	51.2	49	65.8	149	144	0	30	30
2015	7	7	22	26	52	0.21	0.016	0.892	0.039	0.036	0	52.9	51.2	64.1	153	148	0	30	29
2015	7	7	22	36	52	0.259	0	0.892	0.033	0.03	0	51.6	51.2	64.5	151	148	0	31	29
2015	7	7	22	46	52	0.23	0.072	0.892	0.033	0.03	0	53.8	52	64.1	155	150	0	30	29
2015	7	7	22	56	52	0.118	-0.013	0.892	0.039	0.036	0	53.3	51.2	62.8	154	148	0	30	29
2015	7	7	23	6	52	0.243	0.03	0.892	0.039	0.036	0	51.6	50.7	67.1	150	147	0	30	29
2015	7	7	23	16	52	0.112	0.052	0.892	0.036	0.033	0	52.5	51.6	64.9	152	149	0	30	29
2015	7	7	23	26	52	0.262	0.016	0.892	0.033	0.03	0	52.9	51.6	64.9	153	150	0	30	30
2015	7	7	23	36	52	0.21	-0.02	0.892	0.043	0.039	0	52	50.7	67.9	151	148	0	30	30
2015	7	7	23	46	52	0.148	0.069	0.892	0.036	0.033	0	51.2	49.9	68.8	149	146	0	30	30
2015	7	7	23	56	52	0.21	-0.033	0.892	0.033	0.03	0	51.6	50.7	67.1	150	147	0	30	29
2015	7	8	0	6	52	0.24	-0.003	0.892	0.039	0.039	0	50.7	49.5	69.2	148	145	0	30	30
2015	7	8	0	16	52	0.203	-0.033	0.892	0.033	0.03	0	50.3	49.5	69.2	147	144	0	30	29
2015	7	8	0	26	52	0.19	-0.023	0.892	0.033	0.03	0	50.3	49	69.7	147	144	0	30	30
2015	7	8	0	36	52	0.236	0	0.892	0.036	0.033	0	49.5	48.6	68.4	145	142	0	30	29
2015	7	8	0	46	52	0.197	0.036	0.896	0.039	0.036	0	49	48.6	71.8	144	142	0	30	29
2015	7	8	0	56	52	0.259	0	0.892	0.033	0.03	0	48.6	48.6	67.5	143	142	0	30	29
2015	7	8	1	6	52	0.22	-0.007	0.892	0.036	0.033	0	48.6	47.7	70.5	143	141	0	30	30
2015	7	8	1	16	52	0.23	-0.062	0.896	0.033	0.03	0	47.7	47.7	72.2	142	140	0	31	29
2015	7	8	1	26	52	0.213	0	0.892	0.036	0.033	0	47.3	47.3	71.8	140	139	0	30	29
2015	7	8	1	36	52	0.236	0.003	0.896	0.036	0.033	0	48.2	47.3	71.4	142	140	0	30	30
2015	7	8	1	46	52	0.203	0.026	0.892	0.036	0.033	0	47.7	46.9	69.7	142	138	0	31	29
2015	7	8	1	56	52	0.164	0.01	0.896	0.036	0.033	0	49	47.7	69.2	144	141	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	8	2	6	52	0.256	-0.098	0.892	0.039	0.036	0	50.3	48.6	65.8	147	143	0	30	30
2015	7	8	2	16	52	0.236	-0.026	0.896	0.033	0.03	0	48.6	47.3	68.8	143	140	0	30	30
2015	7	8	2	26	52	0.22	0.013	0.896	0.036	0.033	0	49.9	48.2	70.5	146	142	0	30	30
2015	7	8	2	36	52	0.249	0	0.896	0.039	0.036	0	48.6	47.3	68.4	143	140	0	30	30
2015	7	8	2	46	52	0.292	-0.052	0.896	0.039	0.036	0	47.3	46.4	70.5	141	138	0	31	30
2015	7	8	2	56	52	0.233	0.01	0.896	0.036	0.033	0	46.9	46.4	69.7	140	137	0	31	29
2015	7	8	3	6	52	0.226	0.02	0.896	0.036	0.033	0	47.3	46.4	70.5	140	137	0	30	29
2015	7	8	3	16	52	0.197	0.016	0.896	0.036	0.033	0	47.3	46.4	69.2	141	137	0	31	29
2015	7	8	3	26	52	0.18	-0.01	0.896	0.033	0.03	0	47.7	46.4	70.5	141	138	0	30	30
2015	7	8	3	36	52	0.184	-0.03	0.896	0.039	0.036	0	47.7	46.4	70.1	142	138	0	31	30
2015	7	8	3	46	52	0.213	-0.02	0.896	0.036	0.033	0	48.2	46.4	67.9	142	138	0	30	30
2015	7	8	3	56	52	0.174	-0.023	0.896	0.039	0.039	0	48.2	46.4	71	142	138	0	30	30
2015	7	8	4	6	52	0.269	0.007	0.896	0.033	0.03	0	48.6	46.4	68.8	143	138	0	30	30
2015	7	8	4	16	52	0.217	-0.023	0.896	0.033	0.03	0	48.2	46.4	69.7	142	137	0	30	29
2015	7	8	4	26	52	0.177	-0.003	0.896	0.039	0.036	0	47.7	46.9	71	141	138	0	30	29
2015	7	8	4	36	52	0.295	-0.02	0.896	0.039	0.039	0	47.3	45.6	69.7	141	137	0	31	31
2015	7	8	4	46	52	0.226	-0.092	0.896	0.033	0.03	0	46.9	46.4	71.4	140	137	0	31	29
2015	7	8	4	56	52	0.18	-0.043	0.896	0.043	0.039	0	47.3	46.4	72.2	140	137	0	30	29
2015	7	8	5	6	52	0.259	-0.01	0.896	0.039	0.036	0	48.2	46.9	71.4	142	138	0	30	29
2015	7	8	5	16	52	0.2	-0.039	0.896	0.039	0.036	0	47.7	46.9	69.7	142	138	0	31	29
2015	7	8	5	26	52	0.233	0.016	0.896	0.036	0.033	0	47.7	46	72.2	141	137	0	30	30
2015	7	8	5	36	52	0.249	0.016	0.896	0.039	0.036	0	48.6	46.9	69.7	143	139	0	30	30
2015	7	8	5	46	52	0.197	-0.059	0.896	0.036	0.033	0	47.3	46	71	140	137	0	30	30
2015	7	8	5	56	52	0.256	-0.03	0.896	0.039	0.039	0	46.9	45.6	69.2	140	136	0	31	30
2015	7	8	6	6	52	0.19	-0.069	0.896	0.039	0.036	0	47.3	46	70.1	141	137	0	31	30
2015	7	8	6	16	52	0.171	-0.056	0.899	0.039	0.036	0	46	45.2	73.1	138	135	0	31	30
2015	7	8	6	26	52	0.184	-0.03	0.899	0.033	0.03	0	45.6	43.4	73.5	136	131	0	30	30
2015	7	8	6	36	52	0.213	0.023	0.899	0.036	0.033	0	44.7	44.3	73.5	135	133	0	31	30
2015	7	8	6	46	52	0.151	0	0.899	0.039	0.036	0	44.3	43.4	73.1	134	131	0	31	30
2015	7	8	6	56	52	0.217	0.02	0.899	0.039	0.036	0	44.3	43.9	73.1	134	131	0	31	29
2015	7	8	7	6	52	0.246	-0.02	0.899	0.033	0.03	0	44.3	44.3	72.7	134	133	0	31	30
2015	7	8	7	16	52	0.292	-0.003	0.899	0.033	0.03	0	45.6	45.2	72.2	137	135	0	31	30
2015	7	8	7	26	52	0.236	0.052	0.899	0.039	0.036	0	46	45.2	71.8	138	135	0	31	30
2015	7	8	7	36	52	0.259	0.082	0.899	0.036	0.033	0	46	45.6	72.2	138	136	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	8	7	46	52	0.226	-0.066	0.899	0.036	0.033	0	46	45.6	72.7	138	136	0	31	30
2015	7	8	7	56	52	0.246	-0.052	0.899	0.036	0.033	0	44.7	43.9	72.7	134	132	0	30	30
2015	7	8	8	6	52	0.197	0.026	0.899	0.036	0.033	0	45.2	45.2	73.5	136	135	0	31	30
2015	7	8	8	16	52	0.2	0.046	0.899	0.033	0.03	0	45.6	45.2	72.7	137	135	0	31	30
2015	7	8	8	26	52	0.226	0.016	0.899	0.033	0.03	0	46.9	45.2	72.7	139	135	0	30	30
2015	7	8	8	36	52	0.302	0.013	0.899	0.043	0.039	0	46.4	45.6	73.1	139	135	0	31	29
2015	7	8	8	46	52	0.187	-0.026	0.899	0.033	0.03	0	46	44.7	73.1	138	135	0	31	31
2015	7	8	8	56	52	0.223	-0.075	0.899	0.043	0.039	0	46.9	46.4	73.5	140	138	0	31	30
2015	7	8	9	6	52	0.203	-0.01	0.899	0.036	0.033	0	46	45.6	73.1	138	136	0	31	30
2015	7	8	9	16	52	0.194	-0.115	0.899	0.043	0.039	0	46.9	45.2	74	139	135	0	30	30
2015	7	8	9	26	52	0.161	-0.026	0.899	0.043	0.039	0	48.2	46.9	73.1	143	139	0	31	30
2015	7	8	9	36	52	0.2	-0.023	0.899	0.039	0.036	0	49.5	48.6	70.5	145	142	0	30	29
2015	7	8	9	46	52	0.207	-0.079	0.899	0.043	0.039	0	48.6	47.7	71.4	143	141	0	30	30
2015	7	8	9	56	52	0.279	-0.039	0.899	0.036	0.033	0	52	49.5	69.7	151	145	0	30	30
2015	7	8	10	6	52	0.18	0.052	0.899	0.033	0.03	0	50.7	49.9	69.7	148	146	0	30	30
2015	7	8	10	16	52	0.213	0.036	0.899	0.033	0.03	0	50.3	48.2	71	147	142	0	30	30
2015	7	8	10	26	52	0.249	0.052	0.899	0.039	0.036	0	51.2	49	70.5	150	144	0	31	30
2015	7	8	10	36	52	0.217	0.033	0.899	0.039	0.036	0	51.2	50.3	70.5	150	147	0	31	30
2015	7	8	10	46	52	0.174	0.039	0.899	0.033	0.03	0	50.7	50.7	71	149	148	0	31	30
2015	7	8	10	56	52	0.24	0.013	0.899	0.036	0.033	0	52	51.6	69.2	151	149	0	30	29
2015	7	8	11	6	52	0.23	0.016	0.899	0.033	0.03	0	52	51.6	70.1	152	151	0	31	31
2015	7	8	11	16	52	0.213	0.052	0.899	0.036	0.033	0	52.9	52.9	69.7	153	153	0	30	30
2015	7	8	11	26	52	0.148	0.059	0.899	0.033	0.03	0	53.3	52.9	68.8	154	153	0	30	30
2015	7	8	11	36	52	0.187	-0.02	0.899	0.033	0.03	0	53.3	53.3	69.2	155	154	0	31	30
2015	7	8	11	46	52	0.184	0.072	0.899	0.039	0.036	0	56.8	55	64.5	163	158	0	31	30
2015	7	8	11	56	52	0.226	0.003	0.899	0.039	0.036	0	55.5	54.6	65.4	160	157	0	31	30
2015	7	8	12	6	52	0.184	0.095	0.899	0.033	0.033	0	56.8	55.9	66.2	162	159	0	30	29
2015	7	8	12	16	52	0.295	0.059	0.899	0.039	0.036	0	56.3	55.9	66.2	162	159	0	31	29
2015	7	8	12	26	52	0.194	0.069	0.896	0.036	0.033	0	56.8	55.9	65.8	162	159	0	30	29
2015	7	8	12	36	52	0.266	0.066	0.899	0.039	0.036	0	57.6	56.3	65.4	164	161	0	30	30
2015	7	8	12	46	52	0.226	0.082	0.899	0.036	0.033	0	58.5	56.8	64.9	167	162	0	31	30
2015	7	8	12	56	52	0.21	0.092	0.899	0.043	0.039	0	58.5	56.3	65.8	167	161	0	31	30
2015	7	8	13	6	52	0.223	0.062	0.899	0.033	0.03	0	58.5	56.8	66.7	166	162	0	30	30
2015	7	8	13	16	52	0.161	0.105	0.896	0.033	0.03	0	58.5	57.2	62.4	166	162	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	8	13	26	52	0.226	0.075	0.899	0.036	0.033	0	59.3	58	62.8	169	164	0	31	29
2015	7	8	13	36	52	0.23	0.092	0.899	0.036	0.033	0	60.2	58.5	63.2	170	165	0	30	29
2015	7	8	13	46	52	0.276	0.069	0.899	0.043	0.039	0	59.8	58.5	60.6	170	165	0	31	29
2015	7	8	13	56	52	0.23	0.085	0.899	0.033	0.03	0	58.9	56.8	63.6	167	162	0	30	30
2015	7	8	14	6	52	0.187	0.007	0.899	0.033	0.03	0	54.2	53.8	67.5	157	155	0	31	30
2015	7	8	14	16	52	0.279	0.036	0.896	0.033	0.03	0	52	52	68.4	151	150	0	30	29
2015	7	8	14	26	52	0.276	0.039	0.899	0.036	0.033	0	52	51.6	68.8	152	150	0	31	30
2015	7	8	14	36	52	0.207	0.026	0.899	0.039	0.039	0	52	51.2	70.5	151	148	0	30	29
2015	7	8	14	46	52	0.262	0.023	0.899	0.039	0.036	0	54.6	52.5	69.2	157	152	0	30	30
2015	7	8	14	56	52	0.269	0.036	0.899	0.033	0.03	0	55	53.8	68.4	159	154	0	31	29
2015	7	8	15	6	52	0.262	0.072	0.896	0.036	0.033	0	50.7	49.9	69.7	149	146	0	31	30
2015	7	8	15	16	52	0.262	-0.01	0.899	0.033	0.03	0	50.7	49	71.4	147	143	0	29	29
2015	7	8	15	26	52	0.259	0.046	0.896	0.03	0.03	0	47.7	46.9	72.2	142	139	0	31	30
2015	7	8	15	36	52	0.236	0.069	0.899	0.039	0.039	0	50.7	49.5	69.7	148	144	0	30	29
2015	7	8	15	46	52	0.135	0.069	0.896	0.033	0.03	0	51.6	49.9	69.7	150	145	0	30	29
2015	7	8	15	56	52	0.282	0.043	0.899	0.036	0.033	0	53.3	50.3	70.1	154	147	0	30	30
2015	7	8	16	6	52	0.266	-0.033	0.896	0.036	0.033	0	50.7	49.9	70.1	148	145	0	30	29
2015	7	8	16	16	52	0.197	0.108	0.896	0.033	0.03	0	48.2	47.3	72.7	142	140	0	30	30
2015	7	8	16	26	52	0.256	-0.003	0.896	0.036	0.033	0	50.3	49.5	70.1	147	144	0	30	29
2015	7	8	16	36	52	0.213	0.095	0.896	0.036	0.033	0	51.6	50.3	69.7	150	146	0	30	29
2015	7	8	16	46	52	0.243	0	0.896	0.039	0.039	0	53.3	51.6	67.5	154	149	0	30	29
2015	7	8	16	56	52	0.157	-0.036	0.896	0.039	0.036	0	50.7	49	70.1	148	144	0	30	30
2015	7	8	17	6	52	0.226	0	0.896	0.036	0.033	0	50.7	49.5	71.4	148	144	0	30	29
2015	7	8	17	16	52	0.269	0.013	0.896	0.043	0.039	0	50.3	48.2	71.4	147	142	0	30	30
2015	7	8	17	26	52	0.24	-0.059	0.896	0.039	0.036	0	51.2	49.5	70.1	149	144	0	30	29
2015	7	8	17	36	52	0.262	-0.036	0.896	0.043	0.039	0	52	49.9	69.7	151	146	0	30	30
2015	7	8	17	46	52	0.23	-0.046	0.896	0.039	0.036	0	52.5	51.2	69.7	152	148	0	30	29
2015	7	8	17	56	52	0.226	-0.023	0.896	0.039	0.036	0	50.3	49.5	71	148	144	0	31	29
2015	7	8	18	6	52	0.226	-0.049	0.896	0.036	0.033	0	50.7	48.6	70.5	148	143	0	30	30
2015	7	8	18	16	52	0.226	-0.016	0.896	0.039	0.036	0	50.3	49	69.7	147	143	0	30	29
2015	7	8	18	26	52	0.213	-0.013	0.896	0.039	0.036	0	50.7	49.5	67.9	148	144	0	30	29
2015	7	8	18	36	52	0.213	0.03	0.896	0.043	0.039	0	54.6	52.5	63.6	157	152	0	30	30
2015	7	8	18	46	52	0.22	0.016	0.896	0.039	0.036	0	58	56.3	61.1	166	160	0	31	29
2015	7	8	18	56	52	0.223	-0.056	0.896	0.033	0.03	0	57.6	55.5	57.2	164	159	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	8	19	6	52	0.233	0.003	0.896	0.039	0.039	0	57.2	55.5	58	163	158	0	30	29
2015	7	8	19	16	52	0.22	0.052	0.892	0.043	0.039	0	55.9	55	58	161	157	0	31	29
2015	7	8	19	26	52	0.253	0.023	0.892	0.039	0.036	0	55.5	54.2	60.6	159	156	0	30	30
2015	7	8	19	36	52	0.223	0.036	0.892	0.036	0.033	0	55	54.2	58.5	159	155	0	31	29
2015	7	8	19	46	52	0.112	0.036	0.892	0.039	0.039	0	56.3	55	55	161	157	0	30	29
2015	7	8	19	56	52	0.22	-0.007	0.892	0.043	0.039	0	55	54.2	60.6	158	155	0	30	29
2015	7	8	20	6	52	0.21	-0.003	0.892	0.039	0.039	0	56.3	54.2	59.3	161	156	0	30	30
2015	7	8	20	16	52	0.18	0.016	0.892	0.043	0.039	0	55.5	54.2	61.5	160	155	0	31	29
2015	7	8	20	26	52	0.177	-0.059	0.892	0.039	0.036	0	55.9	53.3	63.2	160	154	0	30	30
2015	7	8	20	36	52	0.259	0.01	0.892	0.033	0.03	0	55	52.9	61.1	158	153	0	30	30
2015	7	8	20	46	52	0.269	-0.039	0.892	0.039	0.039	0	54.6	53.3	64.1	157	154	0	30	30
2015	7	8	20	56	52	0.253	0.023	0.892	0.039	0.036	0	55	52.9	64.1	157	152	0	29	29
2015	7	8	21	6	52	0.203	-0.016	0.892	0.039	0.036	0	52.9	51.2	66.2	153	148	0	30	29
2015	7	8	21	16	52	0.128	0.049	0.892	0.039	0.036	0	54.6	53.3	59.8	158	154	0	31	30
2015	7	8	21	26	52	0.184	0.072	0.892	0.036	0.033	0	52.5	51.2	66.2	152	148	0	30	29
2015	7	8	21	36	52	0.2	0.033	0.892	0.033	0.03	0	51.6	51.2	64.1	151	149	0	31	30
2015	7	8	21	46	52	0.161	-0.046	0.892	0.036	0.033	0	53.3	52	63.2	154	151	0	30	30
2015	7	8	21	56	52	0.217	0.033	0.889	0.036	0.033	0	51.6	52	63.6	151	150	0	31	29
2015	7	8	22	6	52	0.272	0.056	0.892	0.046	0.043	0	52	51.2	66.2	151	148	0	30	29
2015	7	8	22	16	52	0.184	0.013	0.889	0.039	0.039	0	52	51.2	62.8	151	149	0	30	30
2015	7	8	22	26	52	0.22	0	0.889	0.039	0.036	0	51.6	51.6	62.8	151	150	0	31	30
2015	7	8	22	36	52	0.23	0.046	0.892	0.039	0.036	0	51.2	50.7	66.7	150	148	0	31	30
2015	7	8	22	46	52	0.19	0	0.889	0.036	0.033	0	51.6	50.7	61.5	151	148	0	31	30
2015	7	8	22	56	52	0.18	-0.052	0.889	0.039	0.039	0	53.3	52.9	61.9	155	152	0	31	29
2015	7	8	23	6	52	0.253	0.056	0.889	0.033	0.03	0	53.3	52	61.9	155	152	0	31	31
2015	7	8	23	16	52	0.171	-0.056	0.889	0.033	0.03	0	52.9	52	62.4	154	151	0	31	30
2015	7	8	23	26	52	0.24	-0.013	0.889	0.039	0.039	0	53.8	52.9	63.6	155	153	0	30	30
2015	7	8	23	36	52	0.233	-0.036	0.889	0.036	0.033	0	53.3	52	63.6	154	151	0	30	30
2015	7	8	23	46	52	0.18	0.036	0.889	0.039	0.036	0	51.6	50.3	64.1	150	147	0	30	30
2015	7	8	23	56	52	0.154	0.003	0.889	0.036	0.033	0	50.3	49.9	65.4	148	146	0	31	30
2015	7	9	0	6	52	0.253	0.062	0.889	0.039	0.036	0	50.3	49.9	66.2	147	146	0	30	30
2015	7	9	0	16	52	0.213	-0.01	0.889	0.039	0.036	0	49.5	49.5	66.2	146	145	0	31	30
2015	7	9	0	26	52	0.217	-0.03	0.889	0.046	0.043	0	50.7	50.3	64.1	149	147	0	31	30
2015	7	9	0	36	52	0.243	0.02	0.889	0.039	0.036	0	50.3	49.5	66.7	148	145	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	9	0	46	52	0.177	0.01	0.889	0.039	0.039	0	51.2	50.3	64.5	149	147	0	30	30
2015	7	9	0	56	52	0.135	0	0.889	0.039	0.036	0	49.9	49.9	63.2	147	146	0	31	30
2015	7	9	1	6	52	0.187	-0.033	0.889	0.039	0.036	0	51.2	49.9	64.5	149	146	0	30	30
2015	7	9	1	16	52	0.236	-0.026	0.889	0.033	0.03	0	50.3	49.9	64.9	148	145	0	31	29
2015	7	9	1	26	52	0.23	0.003	0.889	0.036	0.033	0	49.9	49	65.8	147	145	0	31	31
2015	7	9	1	36	52	0.197	-0.052	0.889	0.039	0.039	0	48.6	48.6	68.8	144	142	0	31	29
2015	7	9	1	46	52	0.223	-0.046	0.889	0.036	0.033	0	48.2	48.2	68.8	143	142	0	31	30
2015	7	9	1	56	52	0.217	0	0.889	0.036	0.033	0	47.7	47.3	69.7	142	140	0	31	30
2015	7	9	2	6	52	0.23	-0.056	0.889	0.039	0.039	0	51.2	49.9	66.7	149	146	0	30	30
2015	7	9	2	16	52	0.184	0.079	0.889	0.039	0.039	0	51.6	50.7	64.5	151	148	0	31	30
2015	7	9	2	26	52	0.253	-0.003	0.889	0.036	0.033	0	50.3	49.9	64.9	148	146	0	31	30
2015	7	9	2	36	52	0.266	-0.007	0.889	0.039	0.036	0	50.3	49	65.8	148	144	0	31	30
2015	7	9	2	46	52	0.177	0	0.889	0.039	0.039	0	48.6	48.6	65.4	144	143	0	31	30
2015	7	9	2	56	52	0.194	0.016	0.889	0.039	0.036	0	48.6	48.2	66.7	144	143	0	31	31
2015	7	9	3	6	52	0.184	0.013	0.889	0.036	0.033	0	48.2	47.3	68.4	143	141	0	31	31
2015	7	9	3	16	52	0.276	0.003	0.889	0.036	0.033	0	48.2	48.2	67.1	143	142	0	31	30
2015	7	9	3	26	52	0.223	-0.056	0.889	0.036	0.033	0	48.2	48.2	68.4	144	142	0	32	30
2015	7	9	3	36	52	0.177	0.049	0.889	0.033	0.03	0	48.2	47.7	69.2	143	141	0	31	30
2015	7	9	3	46	52	0.171	-0.003	0.889	0.043	0.039	0	46.9	47.3	67.1	140	140	0	31	30
2015	7	9	3	56	52	0.249	-0.052	0.889	0.046	0.043	0	47.7	46.9	67.9	142	140	0	31	31
2015	7	9	4	6	52	0.226	-0.003	0.889	0.039	0.036	0	46.9	47.3	68.8	141	140	0	32	30
2015	7	9	4	16	52	0.171	-0.026	0.889	0.049	0.046	0	46.4	46.4	70.1	139	138	0	31	30
2015	7	9	4	26	52	0.236	0.036	0.889	0.033	0.03	0	47.3	46.4	67.9	141	139	0	31	31
2015	7	9	4	36	52	0.197	-0.016	0.889	0.039	0.039	0	47.3	46.4	67.9	141	138	0	31	30
2015	7	9	4	46	52	0.226	0	0.889	0.039	0.036	0	46.9	46.4	67.5	140	138	0	31	30
2015	7	9	4	56	52	0.223	0	0.889	0.039	0.039	0	47.3	46.4	67.5	141	139	0	31	31
2015	7	9	5	6	52	0.236	-0.059	0.889	0.039	0.036	0	47.3	46.9	67.9	141	140	0	31	31
2015	7	9	5	16	52	0.266	0.007	0.889	0.033	0.03	0	46.4	46.9	68.8	140	139	0	32	30
2015	7	9	5	26	52	0.226	-0.066	0.889	0.039	0.036	0	48.2	47.3	68.8	143	140	0	31	30
2015	7	9	5	36	52	0.171	-0.003	0.889	0.033	0.03	0	48.6	47.7	67.5	144	141	0	31	30
2015	7	9	5	46	52	0.24	-0.069	0.889	0.039	0.039	0	46	45.2	71.8	138	136	0	31	31
2015	7	9	5	56	52	0.203	0.01	0.889	0.036	0.033	0	44.7	44.7	72.2	135	134	0	31	30
2015	7	9	6	6	52	0.276	-0.01	0.889	0.039	0.036	0	44.3	45.2	73.1	134	135	0	31	30
2015	7	9	6	16	52	0.203	-0.01	0.889	0.033	0.03	0	44.3	43.4	72.2	134	132	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	9	6	26	52	0.269	0.036	0.889	0.033	0.03	0	43	43	72.2	131	131	0	31	31
2015	7	9	6	36	52	0.144	-0.023	0.889	0.033	0.03	0	43.9	43.9	71.8	133	133	0	31	31
2015	7	9	6	46	52	0.2	-0.095	0.889	0.036	0.033	0	43.4	43.4	71.8	133	132	0	32	31
2015	7	9	6	56	52	0.171	0.043	0.889	0.039	0.036	0	43	44.3	72.7	132	133	0	32	30
2015	7	9	7	6	52	0.174	-0.036	0.889	0.046	0.043	0	44.3	44.3	71.8	133	133	0	30	30
2015	7	9	7	16	52	0.223	-0.036	0.889	0.039	0.036	0	44.3	44.3	73.1	134	133	0	31	30
2015	7	9	7	26	52	0.167	-0.03	0.889	0.039	0.036	0	43	43.9	72.7	132	132	0	32	30
2015	7	9	7	36	52	0.19	-0.043	0.889	0.036	0.033	0	44.3	42.6	74.4	133	130	0	30	31
2015	7	9	7	46	52	0.115	-0.072	0.889	0.036	0.033	0	44.7	43	73.5	135	131	0	31	31
2015	7	9	7	56	52	0.233	-0.036	0.889	0.033	0.03	0	43.4	44.3	74.4	132	133	0	31	30
2015	7	9	8	6	52	0.154	-0.059	0.889	0.033	0.03	0	46.9	44.3	74.8	141	134	0	32	31
2015	7	9	8	16	52	0.217	-0.069	0.889	0.036	0.033	0	47.3	44.3	74.8	142	133	0	32	30
2015	7	9	8	26	52	0.197	-0.125	0.889	0.043	0.043	0	45.6	44.7	75.7	137	134	0	31	30
2015	7	9	8	36	52	0.184	-0.036	0.889	0.033	0.03	0	44.7	44.7	74.8	135	134	0	31	30
2015	7	9	8	46	52	0.131	0.036	0.889	0.036	0.033	0	47.7	44.3	74.4	142	134	0	31	31
2015	7	9	8	56	52	0.167	-0.056	0.889	0.033	0.033	0	47.3	45.2	74.4	141	135	0	31	30
2015	7	9	9	6	52	0.118	-0.046	0.889	0.033	0.03	0	46	46	74.8	138	137	0	31	30
2015	7	9	9	16	52	0.226	0.003	0.889	0.036	0.033	0	46	46	75.3	138	137	0	31	30
2015	7	9	9	26	52	0.246	-0.026	0.889	0.039	0.036	0	46.4	45.6	73.5	139	136	0	31	30
2015	7	9	9	36	52	0.22	0.075	0.889	0.049	0.049	0	46.9	44.7	74.4	139	135	0	30	31
2015	7	9	9	46	52	0.348	0.154	0.892	0.043	0.039	0	46.9	46	73.5	140	137	0	31	30
2015	7	9	9	56	52	0.331	0.167	0.889	0.036	0.033	0	47.7	44.7	75.3	142	134	0	31	30
2015	7	9	10	6	52	0.19	0.03	0.889	0.033	0.033	0	50.3	45.2	74.8	148	136	0	31	31
2015	7	9	10	16	52	0.039	-0.194	0.889	0.033	0.03	0	49.5	45.6	75.3	146	136	0	31	30
2015	7	9	10	26	52	0.095	-0.174	0.889	0.039	0.036	0	48.6	45.2	75.3	144	136	0	31	31
2015	7	9	10	36	52	0.072	-0.135	0.889	0.039	0.036	0	46.9	46.4	74.8	140	139	0	31	31
2015	7	9	10	46	52	0.243	0.066	0.889	0.033	0.03	0	51.6	48.2	74.4	150	143	0	30	31
2015	7	9	10	56	52	0.194	-0.03	0.889	0.039	0.036	0	47.7	47.7	73.5	143	141	0	32	30
2015	7	9	11	6	52	0.157	-0.043	0.889	0.039	0.036	0	49.5	50.3	73.1	146	147	0	31	30
2015	7	9	11	16	52	0.184	0	0.889	0.033	0.03	0	48.2	47.3	74.8	144	140	0	32	30
2015	7	9	11	26	52	0.184	-0.089	0.889	0.036	0.033	0	47.3	46.4	74.4	141	138	0	31	30
2015	7	9	11	36	52	0.217	0.03	0.889	0.039	0.036	0	44.3	45.2	74.8	134	135	0	31	30
2015	7	9	11	46	52	0.213	0.092	0.876	0.049	0.046	0	58	59.3	50.3	166	168	0	31	30
2015	7	9	11	56	52	0.226	0.141	0.886	0.043	0.039	0	60.6	60.6	53.3	172	171	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	9	12	6	52	0.249	0.19	0.889	0.039	0.036	0	60.6	59.8	54.2	172	169	0	31	30
2015	7	9	12	16	52	0.246	0.118	0.886	0.039	0.036	0	59.8	59.3	49.9	171	169	0	32	31
2015	7	9	12	26	52	0.167	0.118	0.886	0.049	0.046	0	58.9	58.9	52.9	169	168	0	32	31
2015	7	9	12	36	52	0.213	0.22	0.886	0.043	0.039	0	58.5	58.5	57.2	168	166	0	32	30
2015	7	9	12	46	52	0.213	0.226	0.886	0.039	0.039	0	58	58	58	166	165	0	31	30
2015	7	9	12	56	52	0.207	0.243	0.886	0.039	0.036	0	56.8	56.8	60.2	163	162	0	31	30
2015	7	9	13	6	52	0.207	0.22	0.886	0.039	0.039	0	55	55.5	61.5	160	159	0	32	30
2015	7	9	13	16	52	0.226	0.276	0.886	0.043	0.039	0	53.8	53.8	64.5	157	156	0	32	31
2015	7	9	13	26	52	0.246	0.22	0.886	0.036	0.033	0	52.9	52.9	64.5	155	154	0	32	31
2015	7	9	13	36	52	0.207	0.174	0.886	0.046	0.043	0	53.8	52.9	64.1	156	154	0	31	31
2015	7	9	13	46	52	0.21	0.21	0.886	0.039	0.036	0	54.2	54.2	63.6	158	156	0	32	30
2015	7	9	13	56	52	0.266	0.272	0.886	0.039	0.036	0	55	55	63.2	159	158	0	31	30
2015	7	9	14	6	52	0.161	0.279	0.886	0.036	0.033	0	55.9	55.5	61.5	161	159	0	31	30
2015	7	9	14	16	52	0.164	0.213	0.886	0.043	0.039	0	55.9	56.3	61.5	162	161	0	32	30
2015	7	9	14	26	52	0.161	0.167	0.886	0.043	0.039	0	56.8	55.9	61.1	162	160	0	30	30
2015	7	9	14	36	52	0.22	0.295	0.886	0.043	0.039	0	56.8	56.3	60.6	163	161	0	31	30
2015	7	9	14	46	52	0.18	0.246	0.886	0.039	0.036	0	57.2	56.8	60.6	164	162	0	31	30
2015	7	9	14	56	52	0.157	0.295	0.886	0.036	0.033	0	57.2	57.6	58.5	164	164	0	31	30
2015	7	9	15	6	52	0.135	0.312	0.886	0.039	0.039	0	56.8	56.8	58	163	162	0	31	30
2015	7	9	15	16	52	0.174	0.272	0.886	0.039	0.036	0	56.3	56.3	60.2	162	162	0	31	31
2015	7	9	15	26	52	0.187	0.302	0.883	0.039	0.039	0	56.8	56.3	59.3	162	161	0	30	30
2015	7	9	15	36	52	0.23	0.358	0.883	0.039	0.036	0	55	55.9	60.2	160	160	0	32	30
2015	7	9	15	46	52	0.24	0.282	0.883	0.036	0.033	0	55.5	55.5	60.6	160	158	0	31	29
2015	7	9	15	56	52	0.203	0.308	0.883	0.036	0.033	0	55.9	55	60.6	160	158	0	30	30
2015	7	9	16	6	52	0.19	0.328	0.883	0.039	0.039	0	55.9	55.5	61.9	161	159	0	31	30
2015	7	9	16	16	52	0.148	0.236	0.883	0.043	0.039	0	55.9	55	61.5	160	159	0	30	31
2015	7	9	16	26	52	0.19	0.262	0.883	0.043	0.039	0	53.8	53.8	62.8	156	155	0	31	30
2015	7	9	16	36	52	0.184	0.233	0.883	0.039	0.039	0	54.6	52.5	63.6	158	153	0	31	31
2015	7	9	16	46	52	0.131	0.302	0.883	0.039	0.039	0	53.8	53.3	63.6	156	154	0	31	30
2015	7	9	16	56	52	0.167	0.272	0.883	0.039	0.039	0	55.9	55.5	61.9	161	159	0	31	30
2015	7	9	17	6	52	0.197	0.161	0.883	0.039	0.036	0	56.3	55.5	63.2	162	159	0	31	30
2015	7	9	17	16	52	0.194	0.295	0.883	0.039	0.039	0	55	54.6	62.8	159	157	0	31	30
2015	7	9	17	26	52	0.2	0.256	0.883	0.039	0.036	0	53.8	53.3	64.5	156	155	0	31	31
2015	7	9	17	36	52	0.161	0.295	0.883	0.033	0.03	0	52.5	52.5	65.8	153	152	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	9	17	46	52	0.236	0.249	0.883	0.033	0.03	0	51.6	51.2	65.4	150	149	0	30	30
2015	7	9	17	56	52	0.144	0.272	0.883	0.039	0.036	0	51.6	50.7	65.4	150	148	0	30	30
2015	7	9	18	6	52	0.249	0.161	0.883	0.039	0.036	0	50.3	49.5	66.7	148	146	0	31	31
2015	7	9	18	16	52	0.269	0.121	0.883	0.036	0.033	0	50.7	50.3	66.7	149	147	0	31	30
2015	7	9	18	26	52	0.148	0.154	0.883	0.043	0.039	0	49.5	49	67.9	146	144	0	31	30
2015	7	9	18	36	52	0.19	0.223	0.883	0.036	0.033	0	49	48.6	67.9	145	143	0	31	30
2015	7	9	18	46	52	0.24	0.105	0.883	0.039	0.039	0	48.6	48.6	67.1	144	143	0	31	30
2015	7	9	18	56	52	0.217	0.105	0.883	0.036	0.033	0	47.7	47.7	68.4	142	141	0	31	30
2015	7	9	19	6	52	0.18	0.082	0.879	0.036	0.033	0	48.2	46.9	68.4	142	139	0	30	30
2015	7	9	19	16	52	0.226	0.059	0.883	0.039	0.039	0	47.7	47.7	68.8	142	141	0	31	30
2015	7	9	19	26	52	0.174	0.069	0.883	0.039	0.036	0	46.9	46.4	70.1	140	138	0	31	30
2015	7	9	19	36	52	0.102	0.016	0.883	0.039	0.039	0	46.4	46	70.1	139	137	0	31	30
2015	7	9	19	46	52	0.085	0.049	0.883	0.039	0.036	0	46	45.2	71.4	138	136	0	31	31
2015	7	9	19	56	52	0.131	0.082	0.883	0.036	0.033	0	45.2	44.7	72.2	136	135	0	31	31
2015	7	9	20	6	52	0.207	0.079	0.883	0.036	0.033	0	46.9	47.3	70.5	141	140	0	32	30
2015	7	9	20	16	52	0.213	-0.026	0.879	0.036	0.033	0	48.2	47.7	68.4	143	141	0	31	30
2015	7	9	20	26	52	0.226	-0.003	0.883	0.039	0.039	0	47.7	46.9	68.8	142	140	0	31	31
2015	7	9	20	36	52	0.174	-0.023	0.883	0.039	0.039	0	47.3	47.3	69.7	142	140	0	32	30
2015	7	9	20	46	52	0.19	0.03	0.883	0.036	0.033	0	47.3	46.4	68.8	141	139	0	31	31
2015	7	9	20	56	52	0.24	-0.036	0.879	0.036	0.033	0	48.2	47.3	67.9	142	140	0	30	30
2015	7	9	21	6	52	0.194	-0.043	0.879	0.043	0.039	0	50.7	49.9	65.8	149	147	0	31	31
2015	7	9	21	16	52	0.236	0	0.879	0.046	0.043	0	47.3	46.9	69.2	141	140	0	31	31
2015	7	9	21	26	52	0.171	0.066	0.883	0.033	0.03	0	45.6	46	72.7	138	137	0	32	30
2015	7	9	21	36	52	0.243	0.016	0.879	0.033	0.03	0	46.9	47.3	69.2	141	140	0	32	30
2015	7	9	21	46	52	0.213	-0.082	0.883	0.036	0.033	0	45.2	45.2	71.8	136	135	0	31	30
2015	7	9	21	56	52	0.184	-0.052	0.879	0.039	0.036	0	46	45.2	72.7	138	135	0	31	30
2015	7	9	22	6	52	0.21	0.016	0.879	0.039	0.036	0	44.7	44.7	72.7	134	134	0	30	30
2015	7	9	22	16	52	0.112	0.033	0.883	0.043	0.039	0	44.7	44.3	73.1	135	133	0	31	30
2015	7	9	22	26	52	0.213	0.098	0.883	0.039	0.039	0	43.9	43.9	73.5	133	132	0	31	30
2015	7	9	22	36	52	0.194	0.052	0.883	0.036	0.033	0	45.2	44.7	72.7	136	134	0	31	30
2015	7	9	22	46	52	0.121	-0.016	0.883	0.043	0.039	0	43.9	44.7	73.5	133	133	0	31	29
2015	7	9	22	56	52	0.197	0.069	0.883	0.039	0.039	0	44.3	44.3	74	134	133	0	31	30
2015	7	9	23	6	52	0.226	0.102	0.883	0.043	0.039	0	43.9	43.9	73.1	133	133	0	31	31
2015	7	9	23	16	52	0.226	-0.016	0.883	0.033	0.03	0	44.7	44.3	71.8	135	133	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	9	23	26	52	0.243	0.069	0.883	0.036	0.033	0	44.3	44.3	72.7	133	134	0	30	31
2015	7	9	23	36	52	0.19	0.033	0.883	0.039	0.039	0	43.4	43.9	73.5	132	132	0	31	30
2015	7	9	23	46	52	0.2	0.033	0.883	0.039	0.039	0	43.4	43.4	72.7	133	131	0	32	30
2015	7	9	23	56	52	0.21	-0.03	0.879	0.033	0.03	0	43	43.4	73.5	132	132	0	32	31
2015	7	10	0	6	52	0.18	0.02	0.879	0.036	0.033	0	43.9	43.4	72.7	133	132	0	31	31
2015	7	10	0	16	52	0.21	0.052	0.879	0.033	0.03	0	43.9	43.9	73.5	133	132	0	31	30
2015	7	10	0	26	52	0.194	0	0.883	0.043	0.043	0	43.4	43.9	74	132	132	0	31	30
2015	7	10	0	36	52	0.18	-0.02	0.879	0.039	0.039	0	44.3	43.4	73.1	134	132	0	31	31
2015	7	10	0	46	52	0.21	-0.03	0.879	0.033	0.03	0	43	43	73.1	132	131	0	32	31
2015	7	10	0	56	52	0.21	0.03	0.879	0.039	0.036	0	43	43.4	73.1	131	131	0	31	30
2015	7	10	1	6	52	0.22	-0.033	0.879	0.036	0.033	0	44.3	43.9	73.5	134	132	0	31	30
2015	7	10	1	16	52	0.223	-0.036	0.879	0.039	0.039	0	42.1	43	74	129	131	0	31	31
2015	7	10	1	26	52	0.167	-0.007	0.879	0.039	0.036	0	42.6	43	74	130	130	0	31	30
2015	7	10	1	36	52	0.217	0.046	0.879	0.036	0.033	0	42.6	42.6	73.5	130	129	0	31	30
2015	7	10	1	46	52	0.144	-0.056	0.879	0.039	0.036	0	43	42.1	73.5	131	129	0	31	31
2015	7	10	1	56	52	0.187	0.02	0.879	0.039	0.036	0	43.4	43	73.5	132	130	0	31	30
2015	7	10	2	6	52	0.226	-0.085	0.879	0.046	0.043	0	43.4	43	73.1	132	130	0	31	30
2015	7	10	2	16	52	0.18	0.016	0.879	0.033	0.03	0	43.4	42.6	74	132	130	0	31	31
2015	7	10	2	26	52	0.213	0.059	0.879	0.036	0.033	0	43	43	73.1	131	131	0	31	31
2015	7	10	2	36	52	0.148	-0.052	0.879	0.033	0.03	0	42.1	43.4	73.5	130	132	0	32	31
2015	7	10	2	46	52	0.19	0.085	0.879	0.039	0.039	0	43.4	43	73.1	132	131	0	31	31
2015	7	10	2	56	52	0.249	-0.062	0.879	0.039	0.036	0	43.9	43	72.7	133	131	0	31	31
2015	7	10	3	6	52	0.102	-0.066	0.879	0.043	0.043	0	44.3	43.9	72.7	134	132	0	31	30
2015	7	10	3	16	52	0.174	0.013	0.879	0.036	0.033	0	43.4	43	73.1	132	130	0	31	30
2015	7	10	3	26	52	0.19	-0.01	0.879	0.036	0.033	0	43.9	43.4	73.1	133	131	0	31	30
2015	7	10	3	36	52	0.167	0.023	0.879	0.039	0.036	0	43.9	43	73.5	133	131	0	31	31
2015	7	10	3	46	52	0.171	0	0.879	0.043	0.039	0	43	43	73.5	132	131	0	32	31
2015	7	10	3	56	52	0.187	-0.066	0.879	0.036	0.033	0	43	43.4	73.1	131	131	0	31	30
2015	7	10	4	6	52	0.148	0.01	0.879	0.036	0.033	0	43	42.1	74	131	129	0	31	31
2015	7	10	4	16	52	0.23	0.033	0.879	0.036	0.033	0	43.4	43	73.1	131	130	0	30	30
2015	7	10	4	26	52	0.112	-0.046	0.879	0.039	0.036	0	43.4	43.4	73.5	133	131	0	32	30
2015	7	10	4	36	52	0.19	-0.023	0.879	0.052	0.049	0	43.4	42.6	73.1	132	130	0	31	31
2015	7	10	4	46	52	0.144	-0.089	0.879	0.033	0.03	0	43.9	42.6	73.5	133	130	0	31	31
2015	7	10	4	56	52	0.19	0.056	0.879	0.036	0.033	0	43.9	42.6	73.1	133	130	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	10	5	6	52	0.217	0.007	0.879	0.039	0.036	0	42.6	42.6	73.5	131	130	0	32	31
2015	7	10	5	16	52	0.135	0.016	0.876	0.039	0.039	0	44.3	43	73.1	133	131	0	30	31
2015	7	10	5	26	52	0.213	0	0.876	0.039	0.039	0	43.4	43	72.7	132	131	0	31	31
2015	7	10	5	36	52	0.203	-0.043	0.876	0.039	0.039	0	46.9	46.4	69.2	140	138	0	31	30
2015	7	10	5	46	52	0.161	0.007	0.876	0.043	0.039	0	46.4	44.7	69.7	139	136	0	31	32
2015	7	10	5	56	52	0.164	-0.026	0.876	0.039	0.039	0	44.3	43	71.4	134	130	0	31	30
2015	7	10	6	6	52	0.259	-0.023	0.876	0.039	0.036	0	43.4	42.1	74	132	129	0	31	31
2015	7	10	6	16	52	0.246	-0.01	0.876	0.039	0.036	0	42.6	42.6	73.5	131	129	0	32	30
2015	7	10	6	26	52	0.118	-0.033	0.876	0.033	0.03	0	43.9	43.4	73.1	133	131	0	31	30
2015	7	10	6	36	52	0.154	0	0.876	0.036	0.033	0	43.4	42.6	73.5	132	129	0	31	30
2015	7	10	6	46	52	0.187	0.01	0.876	0.039	0.036	0	42.1	41.3	74	130	127	0	32	31
2015	7	10	6	56	52	0.174	0.036	0.876	0.036	0.033	0	42.1	41.7	73.5	130	128	0	32	31
2015	7	10	7	6	52	0.118	-0.036	0.876	0.039	0.036	0	42.1	41.3	73.5	129	127	0	31	31
2015	7	10	7	16	52	0.141	0.033	0.876	0.039	0.036	0	41.7	42.1	74	129	128	0	32	30
2015	7	10	7	26	52	0.184	0.049	0.876	0.039	0.036	0	42.1	41.7	73.5	129	128	0	31	31
2015	7	10	7	36	52	0.308	0.108	0.876	0.033	0.03	0	43.9	43	72.2	134	131	0	32	31
2015	7	10	7	46	52	0.174	-0.036	0.876	0.033	0.03	0	42.6	41.7	73.1	130	128	0	31	31
2015	7	10	7	56	52	0.272	0.072	0.876	0.043	0.039	0	43.9	42.6	73.1	133	130	0	31	31
2015	7	10	8	6	52	0.24	0.03	0.876	0.039	0.036	0	45.6	44.3	72.2	137	134	0	31	31
2015	7	10	8	16	52	0.089	-0.052	0.876	0.036	0.033	0	44.3	44.7	72.2	134	134	0	31	30
2015	7	10	8	26	52	0.253	0.148	0.873	0.033	0.03	0	45.6	44.3	72.2	138	133	0	32	30
2015	7	10	8	36	52	0.098	-0.121	0.873	0.033	0.03	0	44.3	43.4	73.1	134	131	0	31	30
2015	7	10	8	46	52	0.121	-0.085	0.873	0.043	0.039	0	45.2	44.7	72.2	137	134	0	32	30
2015	7	10	8	56	52	0.046	-0.066	0.873	0.033	0.03	0	46.4	44.7	71.8	140	134	0	32	30
2015	7	10	9	6	52	0.148	-0.036	0.873	0.033	0.03	0	48.2	46.4	71	143	138	0	31	30
2015	7	10	9	16	52	0.249	0.095	0.873	0.036	0.033	0	47.3	46	71	141	138	0	31	31
2015	7	10	9	26	52	0.148	0.141	0.873	0.033	0.03	0	51.2	47.7	69.2	150	141	0	31	30
2015	7	10	9	36	52	0.174	-0.049	0.873	0.039	0.036	0	49	47.7	69.7	145	141	0	31	30
2015	7	10	9	46	52	0.157	0.023	0.873	0.036	0.033	0	49.5	47.3	70.1	147	140	0	32	30
2015	7	10	9	56	52	0.131	0.098	0.876	0.039	0.039	0	65.8	64.9	49.9	184	181	0	31	30
2015	7	10	10	6	52	0.226	0.131	0.879	0.039	0.039	0	63.6	61.1	58	180	172	0	32	30
2015	7	10	10	16	52	0.177	0.062	0.873	0.033	0.03	0	64.5	62.4	51.6	182	176	0	32	31
2015	7	10	10	26	52	0.217	0.102	0.869	0.033	0.03	0	62.4	62.4	57.2	176	175	0	31	30
2015	7	10	10	36	52	0.177	0.043	0.869	0.039	0.036	0	61.5	61.9	57.2	175	174	0	32	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	10	10	46	52	0.226	0.026	0.866	0.036	0.033	0	61.5	61.1	57.2	174	173	0	31	31
2015	7	10	10	56	52	0.118	0.079	0.866	0.036	0.033	0	61.9	61.5	58	175	174	0	31	31
2015	7	10	11	6	52	0.121	0.01	0.866	0.033	0.03	0	62.4	61.1	56.8	176	173	0	31	31
2015	7	10	11	16	52	0.167	0	0.863	0.039	0.039	0	61.9	62.8	57.6	175	175	0	31	29
2015	7	10	11	26	52	0.148	0.138	0.863	0.033	0.03	0	62.4	61.9	58.5	176	174	0	31	30
2015	7	10	11	36	52	0.154	0.066	0.863	0.043	0.039	0	61.5	61.5	59.3	174	173	0	31	30
2015	7	10	11	46	52	0.223	0.125	0.863	0.036	0.033	0	62.4	61.5	58	175	174	0	30	31
2015	7	10	11	56	52	0.161	0.092	0.86	0.033	0.03	0	62.8	61.5	58.9	177	173	0	31	30
2015	7	10	12	6	52	0.213	0.03	0.86	0.036	0.033	0	62.4	61.9	59.3	176	174	0	31	30
2015	7	10	12	16	52	0.18	0.121	0.86	0.046	0.043	0	62.8	61.5	58	177	174	0	31	31
2015	7	10	12	26	52	0.171	0.059	0.86	0.046	0.043	0	61.9	60.2	61.1	175	171	0	31	31
2015	7	10	12	36	52	0.213	0.023	0.86	0.033	0.03	0	58.5	57.6	63.2	167	164	0	31	30
2015	7	10	12	46	52	0.24	0.089	0.863	0.039	0.036	0	64.5	62.8	58.5	180	176	0	30	30
2015	7	10	12	56	52	0.157	0.095	0.86	0.043	0.039	0	63.6	62.8	58	179	177	0	31	31
2015	7	10	13	6	52	0.105	0.02	0.86	0.043	0.039	0	63.6	62.4	58	179	175	0	31	30
2015	7	10	13	16	52	0.203	0.105	0.86	0.039	0.039	0	64.1	62.8	58	180	176	0	31	30
2015	7	10	13	26	52	0.079	0.112	0.86	0.036	0.033	0	62.8	61.5	59.3	177	174	0	31	31
2015	7	10	13	36	52	0.2	0.092	0.86	0.039	0.036	0	63.6	62.4	59.3	178	175	0	30	30
2015	7	10	13	46	52	0.108	0.125	0.86	0.033	0.03	0	59.3	59.3	62.8	169	168	0	31	30
2015	7	10	13	56	52	0.236	0.121	0.86	0.039	0.039	0	61.1	58.9	61.1	173	168	0	31	31
2015	7	10	14	6	52	0.184	0.03	0.86	0.039	0.039	0	61.9	59.8	61.5	175	169	0	31	30
2015	7	10	14	16	52	0.144	0.033	0.86	0.039	0.036	0	61.1	59.3	62.4	173	168	0	31	30
2015	7	10	14	26	52	0.177	0.052	0.86	0.039	0.036	0	61.1	58.5	61.5	172	166	0	30	30
2015	7	10	14	36	52	0.148	0.052	0.86	0.036	0.033	0	60.2	57.6	63.6	170	164	0	30	30
2015	7	10	14	46	52	0.105	0.082	0.856	0.033	0.03	0	57.2	56.3	67.5	164	160	0	31	29
2015	7	10	14	56	52	0.24	-0.013	0.86	0.036	0.033	0	58.9	55.9	66.2	167	160	0	30	30
2015	7	10	15	6	52	0.243	0.164	0.86	0.039	0.036	0	60.2	58.5	63.2	171	166	0	31	30
2015	7	10	15	16	52	0.164	0.036	0.86	0.039	0.036	0	60.6	58.5	62.8	171	166	0	30	30
2015	7	10	15	26	52	0.154	0.036	0.856	0.036	0.033	0	57.6	56.3	65.4	165	161	0	31	30
2015	7	10	15	36	52	0.197	0.079	0.856	0.036	0.033	0	55.9	55	67.1	161	157	0	31	29
2015	7	10	15	46	52	0.108	0.01	0.856	0.043	0.039	0	52.5	52	68.4	153	150	0	31	29
2015	7	10	15	56	52	0.151	-0.046	0.856	0.036	0.033	0	49.9	48.6	72.2	147	143	0	31	30
2015	7	10	16	6	52	0.19	0.016	0.856	0.046	0.043	0	49.5	48.6	71	145	143	0	30	30
2015	7	10	16	16	52	0.148	0.066	0.856	0.039	0.036	0	50.3	49.5	68.8	148	145	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	10	16	26	52	0.22	0.033	0.853	0.039	0.036	0	50.7	49.9	67.9	148	146	0	30	30
2015	7	10	16	36	52	0.135	0.03	0.853	0.039	0.039	0	54.6	53.3	63.2	158	154	0	31	30
2015	7	10	16	46	52	0.128	0.075	0.85	0.039	0.036	0	54.2	53.8	61.1	157	155	0	31	30
2015	7	10	16	56	52	0.141	0.102	0.853	0.043	0.039	0	55	53.3	64.1	158	154	0	30	30
2015	7	10	17	6	52	0.236	0.125	0.853	0.043	0.039	0	55	54.2	63.6	158	155	0	30	29
2015	7	10	17	16	52	0.2	0.118	0.853	0.046	0.043	0	55	54.2	61.1	159	156	0	31	30
2015	7	10	17	26	52	0.066	0.108	0.853	0.043	0.039	0	55.9	54.6	61.5	160	157	0	30	30
2015	7	10	17	36	52	0.167	0.223	0.856	0.043	0.039	0	55.9	54.6	62.8	160	157	0	30	30
2015	7	10	17	46	52	0.266	0.197	0.853	0.043	0.039	0	55	54.6	63.2	159	156	0	31	29
2015	7	10	17	56	52	0.21	0.148	0.856	0.046	0.043	0	54.2	52.9	65.8	157	153	0	31	30
2015	7	10	18	6	52	0.213	0.089	0.856	0.039	0.036	0	54.2	53.3	66.2	156	153	0	30	29
2015	7	10	18	16	52	0.151	0.207	0.856	0.039	0.036	0	53.3	52	67.1	155	151	0	31	30
2015	7	10	18	26	52	0.148	0.043	0.856	0.043	0.039	0	52.5	51.6	67.1	153	149	0	31	29
2015	7	10	18	36	52	0.164	0.161	0.856	0.039	0.036	0	51.2	50.3	68.4	150	147	0	31	30
2015	7	10	18	46	52	0.203	0.079	0.856	0.049	0.049	0	53.3	50.7	67.9	154	148	0	30	30
2015	7	10	18	56	52	0.148	0.102	0.853	0.039	0.036	0	51.6	50.7	68.4	151	147	0	31	29
2015	7	10	19	6	52	0.164	0.013	0.856	0.043	0.039	0	53.3	52	66.2	154	151	0	30	30
2015	7	10	19	16	52	0.062	0.013	0.856	0.039	0.036	0	52.9	51.6	66.7	153	150	0	30	30
2015	7	10	19	26	52	0.164	0.007	0.856	0.039	0.039	0	55	53.3	65.4	158	154	0	30	30
2015	7	10	19	36	52	0.105	-0.02	0.856	0.043	0.039	0	54.6	53.8	64.9	158	154	0	31	29
2015	7	10	19	46	52	0.118	0.03	0.856	0.039	0.036	0	53.3	52	66.7	155	151	0	31	30
2015	7	10	19	56	52	0.177	0.098	0.853	0.039	0.036	0	51.6	50.7	67.5	151	148	0	31	30
2015	7	10	20	6	52	0.115	-0.016	0.853	0.039	0.039	0	54.6	52.9	65.4	157	152	0	30	29
2015	7	10	20	16	52	0.174	0.141	0.853	0.039	0.036	0	52	50.7	67.5	151	147	0	30	29
2015	7	10	20	26	52	0.164	0.095	0.853	0.043	0.039	0	52.5	51.6	66.7	153	150	0	31	30
2015	7	10	20	36	52	0.2	0.18	0.853	0.039	0.039	0	51.6	51.2	67.5	151	148	0	31	29
2015	7	10	20	46	52	0.118	0.052	0.853	0.039	0.039	0	51.6	49.9	68.4	150	146	0	30	30
2015	7	10	20	56	52	0.177	0.164	0.853	0.036	0.033	0	51.2	49.9	67.9	150	146	0	31	30
2015	7	10	21	6	52	0.131	0.098	0.853	0.036	0.033	0	51.2	50.3	67.9	150	147	0	31	30
2015	7	10	21	16	52	0.154	0.089	0.853	0.039	0.039	0	50.7	49.5	69.2	149	145	0	31	30
2015	7	10	21	26	52	0.207	0.128	0.853	0.043	0.039	0	49.5	47.3	70.1	145	140	0	30	30
2015	7	10	21	36	52	0.157	0.184	0.853	0.043	0.043	0	48.6	47.3	71.4	144	140	0	31	30
2015	7	10	21	46	52	0.125	0.21	0.853	0.039	0.036	0	47.7	46.9	71.4	142	139	0	31	30
2015	7	10	21	56	52	0.2	0.213	0.853	0.033	0.03	0	48.6	46.4	71	143	139	0	30	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	10	22	6	52	0.187	0.197	0.853	0.039	0.036	0	48.2	46.9	71.8	142	139	0	30	30
2015	7	10	22	16	52	0.174	0.174	0.853	0.043	0.039	0	46.9	46	72.2	140	137	0	31	30
2015	7	10	22	26	52	0.125	0.203	0.853	0.036	0.033	0	46.9	46	73.1	140	137	0	31	30
2015	7	10	22	36	52	0.125	0.089	0.853	0.036	0.033	0	48.6	47.3	70.5	144	140	0	31	30
2015	7	10	22	46	52	0.121	0.026	0.853	0.039	0.036	0	48.2	47.7	71.4	143	141	0	31	30
2015	7	10	22	56	52	0.217	0.128	0.853	0.039	0.039	0	46.9	46	72.7	140	137	0	31	30
2015	7	10	23	6	52	0.141	0.131	0.853	0.036	0.033	0	46.4	46	72.7	139	137	0	31	30
2015	7	10	23	16	52	0.22	0.043	0.853	0.036	0.033	0	47.3	46	72.7	141	137	0	31	30
2015	7	10	23	26	52	0.161	0.026	0.853	0.036	0.033	0	46.4	45.6	73.1	139	136	0	31	30
2015	7	10	23	36	52	0.167	0.056	0.853	0.036	0.033	0	46.4	45.6	73.5	139	135	0	31	29
2015	7	10	23	46	52	0.151	-0.02	0.853	0.039	0.039	0	46.9	45.6	72.2	140	136	0	31	30
2015	7	10	23	56	52	0.085	0.095	0.853	0.039	0.036	0	46.4	45.2	74.4	138	135	0	30	30
2015	7	11	0	6	52	0.098	0.01	0.853	0.033	0.03	0	47.3	46.9	72.7	141	138	0	31	29
2015	7	11	0	16	52	0.105	-0.02	0.853	0.039	0.036	0	46	44.3	74	138	134	0	31	31
2015	7	11	0	26	52	0.092	0.016	0.853	0.036	0.033	0	45.2	45.2	74.4	135	134	0	30	29
2015	7	11	0	36	52	0.121	0.043	0.853	0.039	0.039	0	46.4	46.4	73.1	138	138	0	30	30
2015	7	11	0	46	52	0.217	0.016	0.853	0.039	0.036	0	45.2	44.7	73.5	136	134	0	31	30
2015	7	11	0	56	52	0.141	0.026	0.853	0.039	0.039	0	44.7	44.3	74.8	135	133	0	31	30
2015	7	11	1	6	52	0.184	-0.095	0.853	0.039	0.036	0	45.2	43.9	74.8	135	132	0	30	30
2015	7	11	1	16	52	0.144	0	0.853	0.039	0.036	0	44.7	43.9	74.4	135	132	0	31	30
2015	7	11	1	26	52	0.121	0.01	0.853	0.039	0.036	0	43.9	43.4	75.3	133	131	0	31	30
2015	7	11	1	36	52	0.157	-0.036	0.853	0.033	0.03	0	44.3	43.4	74.8	134	131	0	31	30
2015	7	11	1	46	52	0.069	0	0.853	0.039	0.039	0	44.3	44.3	74.4	134	133	0	31	30
2015	7	11	1	56	52	0.171	-0.026	0.853	0.033	0.03	0	44.3	43.4	75.3	134	131	0	31	30
2015	7	11	2	6	52	0.141	0.007	0.853	0.036	0.033	0	44.3	43	75.3	134	131	0	31	31
2015	7	11	2	16	52	0.141	-0.082	0.853	0.033	0.03	0	44.3	43.4	74.8	134	132	0	31	31
2015	7	11	2	26	52	0.102	-0.013	0.853	0.036	0.033	0	44.3	43.9	74	134	132	0	31	30
2015	7	11	2	36	52	0.154	-0.02	0.853	0.046	0.043	0	44.3	43.9	74	134	132	0	31	30
2015	7	11	2	46	52	0.151	-0.062	0.853	0.039	0.039	0	44.7	43.9	74.8	135	132	0	31	30
2015	7	11	2	56	52	0.141	-0.016	0.853	0.039	0.036	0	44.3	43.4	74	134	131	0	31	30
2015	7	11	3	6	52	0.194	-0.003	0.853	0.039	0.036	0	44.7	44.3	73.5	135	133	0	31	30
2015	7	11	3	16	52	0.187	-0.003	0.853	0.036	0.033	0	43	43.4	75.3	132	131	0	32	30
2015	7	11	3	26	52	0.19	-0.013	0.853	0.036	0.033	0	44.3	43.4	74	134	131	0	31	30
2015	7	11	3	36	52	0.049	-0.023	0.853	0.039	0.039	0	43.9	43	73.1	133	131	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	11	3	46	52	0.125	-0.089	0.853	0.039	0.039	0	43.9	43.4	74.4	133	131	0	31	30
2015	7	11	3	56	52	0.115	-0.059	0.853	0.036	0.033	0	44.7	43.9	73.5	135	132	0	31	30
2015	7	11	4	6	52	0.148	0.01	0.853	0.036	0.033	0	44.7	44.7	73.1	135	134	0	31	30
2015	7	11	4	16	52	0.194	-0.036	0.856	0.039	0.036	0	44.7	44.3	72.7	135	133	0	31	30
2015	7	11	4	26	52	0.19	0.072	0.853	0.033	0.03	0	43.9	43.4	73.1	134	131	0	32	30
2015	7	11	4	36	52	0.187	0.026	0.853	0.039	0.039	0	43.9	43.4	74.4	133	132	0	31	31
2015	7	11	4	46	52	0.138	0	0.853	0.036	0.033	0	44.7	43.4	73.1	134	131	0	30	30
2015	7	11	4	56	52	0.151	0	0.856	0.039	0.036	0	44.7	43.4	73.1	136	131	0	32	30
2015	7	11	5	6	52	0.19	0.043	0.853	0.043	0.039	0	48.6	47.3	68.4	144	141	0	31	31
2015	7	11	5	16	52	0.102	-0.016	0.856	0.039	0.036	0	46.4	46	71	139	137	0	31	30
2015	7	11	5	26	52	0.194	0.007	0.856	0.039	0.036	0	46	45.2	71	138	136	0	31	31
2015	7	11	5	36	52	0.131	0.016	0.853	0.036	0.033	0	46.9	46	70.5	140	137	0	31	30
2015	7	11	5	46	52	0.102	0	0.856	0.046	0.043	0	46	44.7	71.4	137	134	0	30	30
2015	7	11	5	56	52	0.174	-0.01	0.856	0.036	0.033	0	45.6	44.7	71.8	137	134	0	31	30
2015	7	11	6	6	52	0.066	-0.016	0.853	0.036	0.033	0	44.7	44.3	71.4	136	133	0	32	30
2015	7	11	6	16	52	0.125	0.003	0.856	0.039	0.039	0	45.2	44.7	71.8	136	134	0	31	30
2015	7	11	6	26	52	0.157	0.003	0.856	0.043	0.039	0	44.3	43.9	71.8	135	132	0	32	30
2015	7	11	6	36	52	0.144	0	0.853	0.039	0.039	0	46	44.7	71.8	138	134	0	31	30
2015	7	11	6	46	52	0.102	-0.085	0.853	0.036	0.033	0	45.6	45.2	71	137	135	0	31	30
2015	7	11	6	56	52	0.095	-0.069	0.853	0.036	0.033	0	47.3	46.4	69.7	141	138	0	31	30
2015	7	11	7	6	52	0.085	0	0.853	0.036	0.033	0	47.3	46.4	70.5	141	138	0	31	30
2015	7	11	7	16	52	0.102	-0.066	0.856	0.039	0.039	0	44.3	43	73.1	134	130	0	31	30
2015	7	11	7	26	52	0.157	-0.059	0.856	0.036	0.033	0	43.4	43	74	133	130	0	32	30
2015	7	11	7	36	52	0.18	-0.052	0.856	0.039	0.036	0	45.2	43.4	72.7	136	131	0	31	30
2015	7	11	7	46	52	0.138	0	0.856	0.033	0.03	0	43	42.6	74.4	131	130	0	31	31
2015	7	11	7	56	52	0.151	0.046	0.856	0.036	0.033	0	46	45.2	72.7	137	135	0	30	30
2015	7	11	8	6	52	0.18	0.026	0.856	0.036	0.033	0	44.7	45.2	73.1	136	136	0	32	31
2015	7	11	8	16	52	0.108	0.016	0.856	0.033	0.03	0	46	46.4	73.1	138	138	0	31	30
2015	7	11	8	26	52	0.203	0.033	0.856	0.036	0.033	0	48.2	47.3	71.4	143	140	0	31	30
2015	7	11	8	36	52	0.177	0.03	0.856	0.039	0.036	0	49	48.6	71	145	143	0	31	30
2015	7	11	8	46	52	0.148	0.003	0.856	0.036	0.033	0	49.9	48.6	68.8	146	144	0	30	31
2015	7	11	8	56	52	0.144	-0.016	0.856	0.039	0.036	0	51.2	50.3	67.9	150	148	0	31	31
2015	7	11	9	6	52	0.154	0.016	0.856	0.033	0.03	0	49.9	49	71	147	144	0	31	30
2015	7	11	9	16	52	0.174	0	0.856	0.039	0.036	0	50.7	49.5	68.8	149	146	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	11	9	26	52	0.105	0.023	0.856	0.039	0.036	0	51.6	49.9	69.2	151	146	0	31	30
2015	7	11	9	36	52	0.177	0	0.856	0.039	0.039	0	49	49.5	71.4	145	145	0	31	30
2015	7	11	9	46	52	0.135	0.016	0.856	0.046	0.043	0	48.6	48.6	72.2	144	143	0	31	30
2015	7	11	9	56	52	0.194	0.043	0.856	0.033	0.03	0	49.9	48.6	71.8	147	144	0	31	31
2015	7	11	10	6	52	0.157	0.082	0.856	0.039	0.036	0	51.6	51.2	70.1	151	149	0	31	30
2015	7	11	10	16	52	0.131	0.052	0.856	0.039	0.039	0	51.6	52	71	151	151	0	31	30
2015	7	11	10	26	52	0.223	0.033	0.856	0.033	0.03	0	51.6	52	70.5	151	151	0	31	30
2015	7	11	10	36	52	0.177	0.039	0.856	0.039	0.036	0	52.9	52.5	69.2	154	152	0	31	30
2015	7	11	10	46	52	0.154	0.059	0.856	0.036	0.033	0	52.5	54.2	70.1	154	156	0	32	30
2015	7	11	10	56	52	0.217	0.052	0.856	0.033	0.03	0	53.3	53.8	69.2	155	155	0	31	30
2015	7	11	11	6	52	0.174	0.046	0.856	0.033	0.03	0	54.2	54.2	68.4	157	156	0	31	30
2015	7	11	11	16	52	0.151	0.023	0.856	0.039	0.036	0	54.6	55	67.9	158	158	0	31	30
2015	7	11	11	26	52	0.18	0.013	0.856	0.033	0.03	0	55.5	55.9	67.9	160	160	0	31	30
2015	7	11	11	36	52	0.246	0.016	0.856	0.039	0.036	0	55.9	55.9	69.7	161	160	0	31	30
2015	7	11	11	46	52	0.141	0.062	0.856	0.033	0.03	0	56.3	55.9	67.1	162	160	0	31	30
2015	7	11	11	56	52	0.161	0.072	0.856	0.036	0.033	0	57.2	56.3	67.5	164	161	0	31	30
2015	7	11	12	6	52	0.18	0.072	0.856	0.033	0.03	0	57.6	56.8	65.4	165	162	0	31	30
2015	7	11	12	16	52	0.154	0.043	0.853	0.039	0.036	0	57.2	56.8	64.9	165	162	0	32	30
2015	7	11	12	26	52	0.197	0.01	0.856	0.033	0.03	0	59.8	58	64.5	170	165	0	31	30
2015	7	11	12	36	52	0.135	0.085	0.856	0.033	0.03	0	59.8	58	64.5	169	165	0	30	30
2015	7	11	12	46	52	0.112	0.052	0.856	0.046	0.043	0	59.8	58.9	64.1	170	167	0	31	30
2015	7	11	12	56	52	0.207	0.056	0.853	0.039	0.036	0	60.2	58	65.4	171	165	0	31	30
2015	7	11	13	6	52	0.174	0.039	0.853	0.036	0.033	0	55.5	54.6	67.9	159	157	0	30	30
2015	7	11	13	16	52	0.167	0.033	0.856	0.033	0.03	0	59.8	58.5	64.1	170	166	0	31	30
2015	7	11	13	26	52	0.148	0.082	0.856	0.036	0.033	0	61.1	59.8	63.2	172	169	0	30	30
2015	7	11	13	36	52	0.157	0.079	0.856	0.039	0.036	0	61.1	59.3	61.5	173	168	0	31	30
2015	7	11	13	46	52	0.23	0.056	0.856	0.036	0.033	0	60.6	59.3	63.2	172	167	0	31	29
2015	7	11	13	56	52	0.184	0.052	0.856	0.033	0.03	0	60.2	58.5	64.1	171	165	0	31	29
2015	7	11	14	6	52	0.177	0.089	0.856	0.036	0.033	0	61.5	59.8	62.4	174	169	0	31	30
2015	7	11	14	16	52	0.151	0.056	0.856	0.036	0.033	0	59.3	57.6	65.8	168	163	0	30	29
2015	7	11	14	26	52	0.171	0.01	0.856	0.036	0.033	0	56.8	55.9	67.9	163	159	0	31	29
2015	7	11	14	36	52	0.151	0.085	0.856	0.046	0.043	0	59.8	56.3	65.4	169	161	0	30	30
2015	7	11	14	46	52	0.174	0.016	0.856	0.036	0.033	0	58.9	55.9	67.1	167	160	0	30	30
2015	7	11	14	56	52	0.243	0.112	0.856	0.033	0.03	0	62.8	60.6	60.6	177	171	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	11	15	6	52	0.223	0.049	0.856	0.033	0.03	0	61.5	59.8	62.8	173	168	0	30	29
2015	7	11	15	16	52	0.2	0.033	0.856	0.043	0.039	0	61.9	59.3	61.9	174	168	0	30	30
2015	7	11	15	26	52	0.171	0.036	0.856	0.036	0.033	0	61.9	60.2	60.2	174	170	0	30	30
2015	7	11	15	36	52	0.171	0.148	0.853	0.039	0.036	0	63.6	60.6	58.5	178	171	0	30	30
2015	7	11	15	46	52	0.141	0.092	0.853	0.039	0.036	0	62.8	60.2	58.9	176	169	0	30	29
2015	7	11	15	56	52	0.151	0.157	0.856	0.039	0.036	0	63.6	61.1	58	178	171	0	30	29
2015	7	11	16	6	52	0.171	0.128	0.853	0.039	0.036	0	61.9	59.3	58.5	174	168	0	30	30
2015	7	11	16	16	52	0.22	0.052	0.853	0.039	0.039	0	61.9	59.3	61.1	174	168	0	30	30
2015	7	11	16	26	52	0.174	0.092	0.853	0.039	0.036	0	63.2	60.2	58	177	169	0	30	29
2015	7	11	16	36	52	0.184	0.066	0.853	0.039	0.039	0	63.2	59.8	60.2	177	168	0	30	29
2015	7	11	16	46	52	0.19	-0.013	0.853	0.033	0.03	0	58.5	56.3	64.5	166	160	0	30	29
2015	7	11	16	56	52	0.167	0.108	0.853	0.036	0.033	0	57.2	54.6	64.9	163	157	0	30	30
2015	7	11	17	6	52	0.174	0.167	0.853	0.033	0.033	0	58.5	55.9	64.5	166	159	0	30	29
2015	7	11	17	16	52	0.131	0.056	0.853	0.03	0.03	0	56.8	54.2	65.8	162	156	0	30	30
2015	7	11	17	26	52	0.144	0.056	0.853	0.033	0.03	0	52.5	51.2	70.1	153	149	0	31	30
2015	7	11	17	36	52	0.128	0.016	0.85	0.033	0.03	0	47.3	46.9	72.2	140	138	0	30	29
2015	7	11	17	46	52	0.207	0	0.85	0.033	0.03	0	46.9	45.2	73.5	139	135	0	30	30
2015	7	11	17	56	52	0.167	0.092	0.85	0.036	0.033	0	49.9	49	69.2	146	143	0	30	29
2015	7	11	18	6	52	0.236	0.135	0.85	0.039	0.036	0	52	50.7	67.1	151	147	0	30	29
2015	7	11	18	16	52	0.177	0.112	0.85	0.039	0.036	0	51.2	50.3	68.4	149	146	0	30	29
2015	7	11	18	26	52	0.112	0.082	0.85	0.043	0.039	0	48.6	46.9	70.1	143	139	0	30	30
2015	7	11	18	36	52	0.256	0.105	0.85	0.039	0.036	0	49	47.3	69.7	144	140	0	30	30
2015	7	11	18	46	52	0.118	0.013	0.85	0.039	0.036	0	48.6	47.3	70.1	143	139	0	30	29
2015	7	11	18	56	52	0.138	0.01	0.85	0.043	0.039	0	49.5	47.7	68.4	146	141	0	31	30
2015	7	11	19	6	52	0.223	0.016	0.85	0.036	0.033	0	50.3	49	68.4	147	143	0	30	29
2015	7	11	19	16	52	0.171	-0.016	0.85	0.036	0.033	0	49.9	48.2	68.8	146	141	0	30	29
2015	7	11	19	26	52	0.131	-0.075	0.85	0.039	0.039	0	49.9	48.6	67.9	146	143	0	30	30
2015	7	11	19	36	52	0.22	0.03	0.85	0.039	0.039	0	52.5	49.9	66.2	152	146	0	30	30
2015	7	11	19	46	52	0.131	-0.089	0.85	0.039	0.039	0	50.7	49.5	67.5	148	144	0	30	29
2015	7	11	19	56	52	0.187	0.02	0.85	0.039	0.039	0	50.3	49	67.9	148	143	0	31	29
2015	7	11	20	6	52	0.141	-0.03	0.85	0.039	0.036	0	52.9	51.6	65.4	153	149	0	30	29
2015	7	11	20	16	52	0.092	-0.059	0.85	0.039	0.039	0	52.5	50.3	66.2	152	147	0	30	30
2015	7	11	20	26	52	0.171	-0.036	0.85	0.043	0.039	0	51.6	49.9	67.5	150	145	0	30	29
2015	7	11	20	36	52	0.223	-0.033	0.85	0.039	0.039	0	50.3	48.6	68.8	147	143	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	11	20	46	52	0.19	-0.131	0.85	0.039	0.039	0	50.7	49.5	69.2	148	144	0	30	29
2015	7	11	20	56	52	0.2	-0.049	0.85	0.039	0.036	0	51.2	49.9	67.1	149	145	0	30	29
2015	7	11	21	6	52	0.174	-0.112	0.85	0.043	0.039	0	51.6	49.9	67.5	150	146	0	30	30
2015	7	11	21	16	52	0.089	-0.013	0.853	0.036	0.033	0	48.2	46.4	71.4	143	138	0	31	30
2015	7	11	21	26	52	0.18	-0.036	0.85	0.039	0.036	0	46	45.2	72.7	138	135	0	31	30
2015	7	11	21	36	52	0.112	-0.036	0.85	0.036	0.033	0	46.9	46	71.4	140	136	0	31	29
2015	7	11	21	46	52	0.243	-0.016	0.85	0.043	0.039	0	48.6	47.7	69.7	143	140	0	30	29
2015	7	11	21	56	52	0.2	0.01	0.85	0.039	0.036	0	47.7	47.3	71	142	139	0	31	29
2015	7	11	22	6	52	0.118	0.023	0.85	0.033	0.03	0	46.4	45.2	72.7	138	135	0	30	30
2015	7	11	22	16	52	0.118	0	0.85	0.039	0.036	0	45.2	43.9	74	136	132	0	31	30
2015	7	11	22	26	52	0.157	-0.036	0.85	0.036	0.033	0	45.6	45.6	74	136	135	0	30	29
2015	7	11	22	36	52	0.187	-0.026	0.85	0.039	0.039	0	44.3	43.4	74	134	131	0	31	30
2015	7	11	22	46	52	0.082	-0.066	0.85	0.036	0.033	0	43.4	43.4	73.5	132	131	0	31	30
2015	7	11	22	56	52	0.128	-0.085	0.85	0.036	0.033	0	46	45.2	72.2	138	135	0	31	30
2015	7	11	23	6	52	0.115	-0.016	0.85	0.039	0.036	0	45.2	44.3	73.1	135	133	0	30	30
2015	7	11	23	16	52	0.246	0.056	0.85	0.033	0.03	0	43.9	43.4	74.8	133	130	0	31	29
2015	7	11	23	26	52	0.072	0.007	0.85	0.03	0.026	0	44.7	43	74.8	134	130	0	30	30
2015	7	11	23	36	52	0.194	-0.059	0.85	0.043	0.039	0	44.3	43.4	74.4	133	131	0	30	30
2015	7	11	23	46	52	0.128	-0.059	0.85	0.036	0.033	0	43.4	43.4	74	131	130	0	30	29
2015	7	11	23	56	52	0.128	-0.089	0.85	0.036	0.033	0	44.7	43.9	74.8	134	132	0	30	30
2015	7	12	0	6	52	0.154	-0.043	0.85	0.036	0.033	0	43.9	43.4	74.8	132	130	0	30	29
2015	7	12	0	16	52	0.059	-0.033	0.85	0.039	0.039	0	43.9	43.4	75.3	132	131	0	30	30
2015	7	12	0	26	52	0.092	-0.003	0.85	0.033	0.03	0	44.7	44.3	74	135	133	0	31	30
2015	7	12	0	36	52	0.082	-0.01	0.85	0.039	0.039	0	43	43	74.8	131	130	0	31	30
2015	7	12	0	46	52	0.095	-0.052	0.85	0.036	0.033	0	46.4	44.7	73.1	139	134	0	31	30
2015	7	12	0	56	52	0.069	0.039	0.85	0.036	0.033	0	45.2	44.7	73.1	136	133	0	31	29
2015	7	12	1	6	52	0.089	0	0.85	0.039	0.036	0	43.9	43	74.4	131	130	0	29	30
2015	7	12	1	16	52	0.2	0	0.85	0.039	0.036	0	43.4	43	74.8	132	130	0	31	30
2015	7	12	1	26	52	0.18	-0.066	0.85	0.039	0.036	0	43	42.6	74.4	131	129	0	31	30
2015	7	12	1	36	52	0.154	-0.052	0.85	0.039	0.039	0	46.4	45.2	72.2	138	135	0	30	30
2015	7	12	1	46	52	0.18	-0.052	0.85	0.039	0.036	0	43.9	43.4	73.5	133	131	0	31	30
2015	7	12	1	56	52	0.154	-0.02	0.85	0.039	0.039	0	44.7	44.7	73.5	135	133	0	31	29
2015	7	12	2	6	52	0.082	-0.033	0.85	0.036	0.033	0	44.7	43.9	73.5	134	132	0	30	30
2015	7	12	2	16	52	0.105	0	0.85	0.036	0.033	0	43.9	42.6	74.4	132	129	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	12	2	26	52	0.128	-0.056	0.85	0.039	0.036	0	44.3	43	74.4	133	130	0	30	30
2015	7	12	2	36	52	0.102	-0.039	0.85	0.039	0.039	0	44.3	43.4	76.1	133	130	0	30	29
2015	7	12	2	46	52	0.033	0	0.85	0.039	0.036	0	43	44.3	74.8	131	132	0	31	29
2015	7	12	2	56	52	0.043	-0.033	0.85	0.033	0.03	0	43.4	43	75.7	132	130	0	31	30
2015	7	12	3	6	52	0.128	-0.03	0.85	0.046	0.043	0	43	43.4	75.3	132	131	0	32	30
2015	7	12	3	16	52	0.125	0.016	0.85	0.036	0.033	0	43.4	42.6	74.8	131	129	0	30	30
2015	7	12	3	26	52	0.085	-0.03	0.85	0.039	0.036	0	43.9	43.4	75.3	132	131	0	30	30
2015	7	12	3	36	52	0.135	-0.007	0.85	0.039	0.039	0	44.3	43.9	74.8	134	132	0	31	30
2015	7	12	3	46	52	0.135	0.023	0.85	0.036	0.033	0	43.4	42.6	75.3	132	129	0	31	30
2015	7	12	3	56	52	0.112	-0.03	0.853	0.039	0.039	0	44.3	43.4	75.7	134	131	0	31	30
2015	7	12	4	6	52	0.089	-0.02	0.85	0.039	0.036	0	43.4	42.6	75.7	131	129	0	30	30
2015	7	12	4	16	52	0.098	-0.036	0.853	0.043	0.039	0	44.3	43.4	75.3	134	132	0	31	31
2015	7	12	4	26	52	0.125	-0.079	0.853	0.039	0.039	0	44.7	44.3	74.4	135	133	0	31	30
2015	7	12	4	36	52	0.121	0.01	0.853	0.036	0.033	0	43.4	43	75.3	132	130	0	31	30
2015	7	12	4	46	52	0.125	0	0.853	0.033	0.03	0	43.4	43.4	75.3	131	130	0	30	29
2015	7	12	4	56	52	0.135	-0.039	0.853	0.036	0.033	0	43.9	43.4	74.8	133	131	0	31	30
2015	7	12	5	6	52	0.102	-0.036	0.853	0.039	0.036	0	43	43.4	75.3	131	131	0	31	30
2015	7	12	5	16	52	0.115	-0.016	0.853	0.036	0.033	0	43.4	43	75.3	132	130	0	31	30
2015	7	12	5	26	52	0.18	-0.026	0.853	0.039	0.036	0	46.4	45.6	72.7	139	136	0	31	30
2015	7	12	5	36	52	0.141	-0.089	0.853	0.039	0.036	0	46	44.3	73.5	137	133	0	30	30
2015	7	12	5	46	52	0.167	-0.007	0.853	0.036	0.033	0	46	44.7	73.1	138	134	0	31	30
2015	7	12	5	56	52	0.174	0.023	0.853	0.036	0.033	0	45.2	44.7	73.1	136	134	0	31	30
2015	7	12	6	6	52	0.157	-0.01	0.853	0.039	0.036	0	45.6	44.3	73.1	137	133	0	31	30
2015	7	12	6	16	52	0.24	-0.03	0.853	0.039	0.039	0	43.4	43	74.8	132	130	0	31	30
2015	7	12	6	26	52	0.115	-0.01	0.853	0.033	0.03	0	46	44.7	72.2	138	135	0	31	31
2015	7	12	6	36	52	0.066	0.013	0.853	0.033	0.03	0	42.6	41.7	74.8	130	126	0	31	29
2015	7	12	6	46	52	0.194	-0.003	0.853	0.036	0.033	0	43.9	43.4	74.4	133	131	0	31	30
2015	7	12	6	56	52	0.118	-0.046	0.853	0.036	0.033	0	43	41.7	74.8	130	128	0	30	31
2015	7	12	7	6	52	0.102	0.003	0.853	0.043	0.039	0	46	44.7	71.8	138	135	0	31	31
2015	7	12	7	16	52	0.085	-0.007	0.856	0.036	0.033	0	45.2	43.9	73.5	136	132	0	31	30
2015	7	12	7	26	52	0.121	-0.108	0.856	0.036	0.033	0	44.7	44.3	73.5	135	133	0	31	30
2015	7	12	7	36	52	0.213	-0.016	0.856	0.036	0.033	0	44.3	43.4	74	134	131	0	31	30
2015	7	12	7	46	52	0.135	-0.007	0.856	0.046	0.043	0	46.9	45.6	72.7	140	135	0	31	29
2015	7	12	7	56	52	0.125	-0.046	0.856	0.036	0.033	0	47.3	46	72.2	141	137	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	12	8	6	52	0.253	-0.016	0.856	0.039	0.039	0	49	48.2	71.8	145	142	0	31	30
2015	7	12	8	16	52	0.23	-0.03	0.856	0.039	0.039	0	49.9	49	71	147	144	0	31	30
2015	7	12	8	26	52	0.118	0	0.856	0.033	0.03	0	50.3	49	69.7	147	145	0	30	31
2015	7	12	8	36	52	0.197	-0.01	0.856	0.039	0.039	0	49.9	49	71.4	147	144	0	31	30
2015	7	12	8	46	52	0.125	-0.003	0.86	0.043	0.043	0	51.6	50.7	69.7	151	148	0	31	30
2015	7	12	8	56	52	0.105	0.033	0.86	0.033	0.03	0	52.5	52.5	68.4	153	152	0	31	30
2015	7	12	9	6	52	0.148	0.016	0.86	0.039	0.036	0	51.2	50.7	69.7	150	148	0	31	30
2015	7	12	9	16	52	0.118	0.016	0.86	0.033	0.03	0	52	50.7	70.1	152	148	0	31	30
2015	7	12	9	26	52	0.066	-0.003	0.86	0.039	0.036	0	52	50.7	70.5	152	148	0	31	30
2015	7	12	9	36	52	0.144	0	0.86	0.039	0.036	0	50.3	49	70.5	148	144	0	31	30
2015	7	12	9	46	52	0.197	-0.007	0.86	0.039	0.036	0	52.9	51.2	69.2	154	149	0	31	30
2015	7	12	9	56	52	0.157	0	0.86	0.036	0.033	0	53.3	51.6	67.9	154	150	0	30	30
2015	7	12	10	6	52	0.118	-0.036	0.86	0.033	0.03	0	52.9	52.9	67.5	154	153	0	31	30
2015	7	12	10	16	52	0.161	-0.01	0.86	0.039	0.036	0	53.3	52	67.9	155	151	0	31	30
2015	7	12	10	26	52	0.105	0.026	0.86	0.033	0.03	0	52	52	69.7	152	151	0	31	30
2015	7	12	10	36	52	0.098	0.072	0.86	0.036	0.033	0	53.8	52	68.4	156	151	0	31	30
2015	7	12	10	46	52	0.125	-0.03	0.86	0.033	0.03	0	55	53.8	66.2	159	155	0	31	30
2015	7	12	10	56	52	0.151	0.016	0.86	0.039	0.036	0	55.5	55.9	67.5	159	160	0	30	30
2015	7	12	11	6	52	0.151	0.039	0.86	0.033	0.03	0	53.3	53.8	68.4	154	155	0	30	30
2015	7	12	11	16	52	0.115	0.121	0.86	0.036	0.033	0	56.8	56.3	65.8	162	161	0	30	30
2015	7	12	11	26	52	0.174	0.108	0.86	0.036	0.033	0	57.2	57.2	64.5	164	163	0	31	30
2015	7	12	11	36	52	0.115	0.066	0.86	0.033	0.03	0	56.8	56.3	65.4	163	161	0	31	30
2015	7	12	11	46	52	0.144	0.033	0.86	0.039	0.039	0	54.2	54.2	68.4	156	156	0	30	30
2015	7	12	11	56	52	0.2	0.085	0.86	0.036	0.033	0	57.2	56.8	64.9	164	162	0	31	30
2015	7	12	12	6	52	0.174	0.007	0.86	0.036	0.033	0	57.6	56.8	64.5	165	162	0	31	30
2015	7	12	12	16	52	0.144	0.016	0.86	0.033	0.03	0	57.2	56.8	64.5	163	162	0	30	30
2015	7	12	12	26	52	0.207	0.102	0.86	0.039	0.036	0	58.9	58	65.4	168	165	0	31	30
2015	7	12	12	36	52	0.184	0.072	0.86	0.036	0.033	0	59.3	58.5	63.2	168	166	0	30	30
2015	7	12	12	46	52	0.144	0.007	0.86	0.033	0.03	0	58.9	58.5	63.6	168	166	0	31	30
2015	7	12	12	56	52	0.236	0.128	0.86	0.039	0.036	0	59.8	58.9	64.5	170	166	0	31	29
2015	7	12	13	6	52	0.164	0.075	0.86	0.033	0.03	0	59.8	58.5	63.2	169	166	0	30	30
2015	7	12	13	16	52	0.223	0.016	0.86	0.033	0.03	0	59.3	58.5	63.6	168	166	0	30	30
2015	7	12	13	26	52	0.177	0.082	0.86	0.039	0.036	0	59.8	59.3	61.5	170	167	0	31	29
2015	7	12	13	36	52	0.213	0.141	0.86	0.036	0.033	0	59.8	58.9	63.6	170	167	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	12	13	46	52	0.197	0.079	0.86	0.036	0.033	0	60.6	58.9	63.2	171	167	0	30	30
2015	7	12	13	56	52	0.233	0.066	0.863	0.036	0.033	0	60.6	59.8	64.1	172	168	0	31	29
2015	7	12	14	6	52	0.177	0.052	0.86	0.036	0.033	0	60.2	59.8	64.1	171	168	0	31	29
2015	7	12	14	16	52	0.164	0.062	0.86	0.033	0.03	0	61.5	59.8	64.1	173	168	0	30	29
2015	7	12	14	26	52	0.171	0.046	0.863	0.036	0.033	0	61.1	60.2	62.4	172	169	0	30	29
2015	7	12	14	36	52	0.22	0.062	0.863	0.043	0.039	0	61.9	60.2	61.5	174	169	0	30	29
2015	7	12	14	46	52	0.22	0.039	0.86	0.039	0.036	0	60.6	59.8	61.9	172	169	0	31	30
2015	7	12	14	56	52	0.21	0.098	0.86	0.033	0.03	0	61.5	60.2	61.1	173	170	0	30	30
2015	7	12	15	6	52	0.151	0.148	0.86	0.036	0.033	0	60.6	59.8	61.1	171	169	0	30	30
2015	7	12	15	16	52	0.167	0.092	0.863	0.033	0.03	0	62.4	60.2	59.8	175	170	0	30	30
2015	7	12	15	26	52	0.233	0.184	0.86	0.036	0.033	0	61.9	60.2	61.1	174	170	0	30	30
2015	7	12	15	36	52	0.151	0.151	0.863	0.039	0.039	0	62.4	60.2	61.5	175	169	0	30	29
2015	7	12	15	46	52	0.098	0.075	0.863	0.039	0.036	0	61.9	61.1	60.6	174	171	0	30	29
2015	7	12	15	56	52	0.131	0.095	0.863	0.039	0.036	0	61.9	59.8	60.2	174	168	0	30	29
2015	7	12	16	6	52	0.154	0.098	0.863	0.033	0.03	0	61.5	60.2	61.9	173	168	0	30	28
2015	7	12	16	16	52	0.207	0.033	0.863	0.036	0.033	0	60.6	58.5	61.5	171	166	0	30	30
2015	7	12	16	26	52	0.167	0.075	0.863	0.039	0.036	0	60.2	58.5	61.5	170	166	0	30	30
2015	7	12	16	36	52	0.102	0.131	0.863	0.043	0.039	0	59.8	58.5	63.6	170	165	0	31	29
2015	7	12	16	46	52	0.118	0.102	0.863	0.039	0.036	0	59.8	58	62.8	169	164	0	30	29
2015	7	12	16	56	52	0.207	0.082	0.863	0.039	0.036	0	59.3	57.2	64.5	168	163	0	30	30
2015	7	12	17	6	52	0.207	0.066	0.863	0.036	0.033	0	58.5	57.2	64.5	166	162	0	30	29
2015	7	12	17	16	52	0.19	0.072	0.863	0.039	0.036	0	56.8	55.9	67.1	162	159	0	30	29
2015	7	12	17	26	52	0.167	0	0.863	0.033	0.03	0	53.3	52.5	68.8	154	151	0	30	29
2015	7	12	17	36	52	0.174	0.013	0.863	0.039	0.039	0	53.8	52	69.7	155	151	0	30	30
2015	7	12	17	46	52	0.161	0.056	0.86	0.033	0.03	0	50.3	49	71	147	144	0	30	30
2015	7	12	17	56	52	0.125	0.016	0.86	0.039	0.036	0	49.9	49	69.7	146	144	0	30	30
2015	7	12	18	6	52	0.21	-0.003	0.86	0.039	0.039	0	49.5	48.6	71	145	142	0	30	29
2015	7	12	18	16	52	0.177	0.01	0.86	0.033	0.033	0	50.3	48.2	70.5	147	141	0	30	29
2015	7	12	18	26	52	0.197	-0.013	0.86	0.039	0.036	0	47.3	46.4	71.8	141	137	0	31	29
2015	7	12	18	36	52	0.167	0.066	0.86	0.039	0.036	0	49	48.2	69.7	145	141	0	31	29
2015	7	12	18	46	52	0.187	0.007	0.86	0.039	0.039	0	50.3	48.6	69.2	147	143	0	30	30
2015	7	12	18	56	52	0.171	-0.033	0.86	0.039	0.039	0	50.7	48.6	67.9	148	143	0	30	30
2015	7	12	19	6	52	0.135	-0.039	0.86	0.039	0.039	0	49	47.7	70.1	144	140	0	30	29
2015	7	12	19	16	52	0.105	-0.003	0.86	0.039	0.036	0	49.5	47.3	70.5	145	139	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	12	19	26	52	0.21	-0.085	0.86	0.036	0.033	0	49.5	46.9	71.4	145	139	0	30	30
2015	7	12	19	36	52	0.112	-0.148	0.86	0.043	0.039	0	48.2	46.4	73.1	142	137	0	30	29
2015	7	12	19	46	52	0.171	-0.062	0.86	0.039	0.036	0	52	49.5	68.8	151	145	0	30	30
2015	7	12	19	56	52	0.112	-0.007	0.86	0.039	0.036	0	53.3	50.7	67.5	154	148	0	30	30
2015	7	12	20	6	52	0.171	-0.069	0.86	0.043	0.039	0	52.9	51.6	66.7	154	149	0	31	29
2015	7	12	20	16	52	0.161	-0.026	0.86	0.046	0.043	0	53.3	51.2	66.2	154	148	0	30	29
2015	7	12	20	26	52	0.187	0.036	0.86	0.036	0.033	0	54.6	53.3	64.9	158	153	0	31	29
2015	7	12	20	36	52	0.233	-0.01	0.863	0.039	0.039	0	52.5	50.7	67.9	152	147	0	30	29
2015	7	12	20	46	52	0.128	-0.066	0.86	0.039	0.036	0	53.8	51.6	66.2	155	150	0	30	30
2015	7	12	20	56	52	0.23	-0.059	0.863	0.043	0.039	0	54.2	52	66.2	156	150	0	30	29
2015	7	12	21	6	52	0.157	-0.007	0.86	0.043	0.039	0	54.2	52.9	65.4	156	152	0	30	29
2015	7	12	21	16	52	0.19	-0.02	0.863	0.039	0.036	0	53.8	52	66.2	155	150	0	30	29
2015	7	12	21	26	52	0.128	-0.059	0.863	0.052	0.049	0	53.8	51.6	66.2	155	149	0	30	29
2015	7	12	21	36	52	0.154	-0.003	0.863	0.039	0.039	0	55.9	53.8	64.1	160	155	0	30	30
2015	7	12	21	46	52	0.102	-0.036	0.863	0.039	0.039	0	51.2	49.5	68.4	148	144	0	29	29
2015	7	12	21	56	52	0.144	0.003	0.863	0.039	0.039	0	50.3	48.6	69.7	147	142	0	30	29
2015	7	12	22	6	52	0.154	-0.026	0.86	0.043	0.043	0	51.6	49.5	68.4	150	145	0	30	30
2015	7	12	22	16	52	0.177	-0.016	0.86	0.046	0.043	0	53.8	52.5	65.4	156	151	0	31	29
2015	7	12	22	26	52	0.21	-0.026	0.86	0.046	0.043	0	49	47.3	70.1	144	140	0	30	30
2015	7	12	22	36	52	0.223	-0.039	0.86	0.039	0.039	0	50.3	48.6	69.2	147	143	0	30	30
2015	7	12	22	46	52	0.082	-0.066	0.86	0.036	0.033	0	51.6	49.9	67.9	150	145	0	30	29
2015	7	12	22	56	52	0.174	-0.036	0.86	0.043	0.043	0	49.9	48.6	69.2	146	142	0	30	29
2015	7	12	23	6	52	0.164	-0.046	0.86	0.049	0.046	0	49.9	47.7	69.2	146	140	0	30	29
2015	7	12	23	16	52	0.141	0.007	0.86	0.039	0.036	0	48.6	48.2	70.5	144	141	0	31	29
2015	7	12	23	26	52	0.118	-0.075	0.86	0.039	0.036	0	48.6	46.9	70.5	143	139	0	30	30
2015	7	12	23	36	52	0.102	-0.023	0.86	0.039	0.039	0	48.2	46.9	71.4	142	139	0	30	30
2015	7	12	23	46	52	0.115	-0.049	0.86	0.039	0.039	0	49	48.2	71	145	141	0	31	29
2015	7	12	23	56	52	0.144	0	0.86	0.039	0.039	0	48.6	46	71.4	143	137	0	30	30
2015	7	13	0	6	52	0.164	-0.039	0.86	0.039	0.039	0	48.2	46.9	71.4	142	138	0	30	29
2015	7	13	0	16	52	0.19	0.03	0.86	0.039	0.036	0	46.9	45.6	72.7	140	136	0	31	30
2015	7	13	0	26	52	0.148	-0.039	0.86	0.043	0.039	0	46	44.7	73.1	137	133	0	30	29
2015	7	13	0	36	52	0.22	-0.052	0.86	0.039	0.036	0	45.6	43.9	74.4	136	132	0	30	30
2015	7	13	0	46	52	0.128	-0.039	0.86	0.036	0.033	0	45.2	44.3	74.4	135	132	0	30	29
2015	7	13	0	56	52	0.203	-0.082	0.86	0.039	0.039	0	45.2	44.3	74.4	135	133	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	13	1	6	52	0.148	-0.082	0.86	0.039	0.036	0	45.2	44.3	74.4	136	133	0	31	30
2015	7	13	1	16	52	0.118	-0.085	0.86	0.036	0.033	0	45.6	43.9	74.4	136	131	0	30	29
2015	7	13	1	26	52	0.108	0.013	0.86	0.036	0.033	0	44.7	42.6	75.3	134	129	0	30	30
2015	7	13	1	36	52	0.085	-0.056	0.86	0.039	0.036	0	44.7	43.9	74.4	134	132	0	30	30
2015	7	13	1	46	52	0.125	-0.043	0.86	0.036	0.033	0	45.2	43.4	74.8	135	131	0	30	30
2015	7	13	1	56	52	0.102	-0.036	0.86	0.036	0.033	0	45.2	43.4	74.4	136	131	0	31	30
2015	7	13	2	6	52	0.112	-0.069	0.856	0.039	0.039	0	45.2	43.4	74	136	131	0	31	30
2015	7	13	2	16	52	0.115	0.01	0.856	0.039	0.036	0	45.2	43.9	74.8	135	132	0	30	30
2015	7	13	2	26	52	0.125	-0.072	0.856	0.039	0.039	0	45.2	43.4	74	136	131	0	31	30
2015	7	13	2	36	52	0.128	-0.069	0.856	0.043	0.039	0	44.7	42.6	74.4	134	129	0	30	30
2015	7	13	2	46	52	0.105	-0.023	0.856	0.039	0.039	0	44.7	43.4	74.8	135	131	0	31	30
2015	7	13	2	56	52	0.118	-0.052	0.856	0.036	0.033	0	44.7	42.1	74.8	134	128	0	30	30
2015	7	13	3	6	52	0.144	0	0.856	0.039	0.036	0	45.6	44.3	74	137	133	0	31	30
2015	7	13	3	16	52	0.03	-0.03	0.856	0.043	0.039	0	45.6	43	74	136	130	0	30	30
2015	7	13	3	26	52	0.154	-0.052	0.856	0.039	0.036	0	45.6	43.9	74.4	136	132	0	30	30
2015	7	13	3	36	52	0.082	-0.033	0.856	0.039	0.039	0	44.7	43	74.8	135	130	0	31	30
2015	7	13	3	46	52	0.131	-0.01	0.856	0.039	0.036	0	46.4	44.3	73.5	138	133	0	30	30
2015	7	13	3	56	52	0.108	-0.056	0.856	0.039	0.036	0	44.7	44.3	74	135	133	0	31	30
2015	7	13	4	6	52	0.105	-0.033	0.856	0.039	0.039	0	44.7	43.9	75.3	135	132	0	31	30
2015	7	13	4	16	52	0.108	-0.108	0.856	0.033	0.03	0	44.7	43	74.8	134	130	0	30	30
2015	7	13	4	26	52	0.105	-0.01	0.856	0.043	0.039	0	47.3	46	71.4	141	137	0	31	30
2015	7	13	4	36	52	0.131	0.01	0.856	0.039	0.036	0	44.7	43.4	74.4	135	131	0	31	30
2015	7	13	4	46	52	0.089	-0.039	0.856	0.033	0.03	0	44.7	43.4	74.8	135	131	0	31	30
2015	7	13	4	56	52	0.121	0.01	0.856	0.036	0.033	0	44.7	43.4	74.8	134	131	0	30	30
2015	7	13	5	6	52	0.148	-0.089	0.856	0.039	0.036	0	45.6	43	74.4	136	130	0	30	30
2015	7	13	5	16	52	0.128	0.013	0.853	0.039	0.036	0	44.7	43	74.8	134	130	0	30	30
2015	7	13	5	26	52	0.2	-0.056	0.853	0.039	0.039	0	45.6	44.3	73.1	137	133	0	31	30
2015	7	13	5	36	52	0.151	-0.03	0.853	0.039	0.036	0	46.9	45.6	72.2	140	136	0	31	30
2015	7	13	5	46	52	0.144	0.02	0.853	0.039	0.036	0	46.9	45.2	73.5	139	134	0	30	29
2015	7	13	5	56	52	0.112	-0.052	0.853	0.036	0.033	0	46.4	45.2	72.7	139	135	0	31	30
2015	7	13	6	6	52	0.125	-0.095	0.853	0.039	0.039	0	45.2	43.9	74.8	136	132	0	31	30
2015	7	13	6	16	52	0.125	-0.02	0.853	0.039	0.036	0	43.9	42.6	74.4	133	129	0	31	30
2015	7	13	6	26	52	0.141	-0.026	0.853	0.046	0.043	0	46.9	45.2	72.2	139	135	0	30	30
2015	7	13	6	36	52	0.141	-0.095	0.853	0.039	0.036	0	43.9	42.6	75.3	133	130	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	13	6	46	52	0.128	0	0.853	0.033	0.03	0	43	41.7	76.1	131	127	0	31	30
2015	7	13	6	56	52	0.151	0.013	0.853	0.033	0.03	0	43	42.6	75.7	131	129	0	31	30
2015	7	13	7	6	52	0.085	0	0.853	0.039	0.036	0	43.4	41.7	75.7	132	127	0	31	30
2015	7	13	7	16	52	0.079	0.007	0.853	0.039	0.036	0	43.4	41.7	76.1	132	127	0	31	30
2015	7	13	7	26	52	0.18	0.052	0.853	0.039	0.036	0	41.7	41.3	76.1	128	126	0	31	30
2015	7	13	7	36	52	0.138	0.026	0.853	0.033	0.03	0	43.4	41.3	76.5	132	126	0	31	30
2015	7	13	7	46	52	0.194	-0.016	0.853	0.039	0.039	0	44.3	41.7	75.7	134	127	0	31	30
2015	7	13	7	56	52	0.174	-0.072	0.853	0.043	0.043	0	44.3	42.6	76.1	134	129	0	31	30
2015	7	13	8	6	52	0.108	0.013	0.856	0.033	0.03	0	45.2	42.1	76.5	136	128	0	31	30
2015	7	13	8	16	52	0.164	0.043	0.856	0.036	0.033	0	43	42.6	76.5	131	130	0	31	31
2015	7	13	8	26	52	0.118	0.016	0.853	0.039	0.036	0	43.4	42.6	76.5	132	130	0	31	31
2015	7	13	8	36	52	0.089	-0.013	0.853	0.036	0.033	0	44.7	43.9	74.8	135	132	0	31	30
2015	7	13	8	46	52	-0.02	-0.112	0.856	0.039	0.036	0	46.9	42.6	76.5	140	129	0	31	30
2015	7	13	8	56	52	0.066	-0.016	0.856	0.033	0.03	0	48.6	46.9	74.4	144	139	0	31	30
2015	7	13	9	6	52	0.085	-0.046	0.856	0.033	0.03	0	51.2	48.6	73.5	149	143	0	30	30
2015	7	13	9	16	52	0.131	0.02	0.856	0.033	0.03	0	49.9	48.6	71.8	147	142	0	31	29
2015	7	13	9	26	52	0.118	-0.052	0.856	0.033	0.03	0	51.2	49	71.8	150	144	0	31	30
2015	7	13	9	36	52	0.085	0.013	0.856	0.033	0.03	0	50.7	49.9	71	150	146	0	32	30
2015	7	13	9	46	52	0.135	0.062	0.856	0.033	0.03	0	50.7	49.5	72.2	149	145	0	31	30
2015	7	13	9	56	52	0.125	0.023	0.856	0.033	0.03	0	51.2	50.3	70.1	150	147	0	31	30
2015	7	13	10	6	52	0.161	-0.046	0.856	0.033	0.03	0	51.6	49	71.8	151	144	0	31	30
2015	7	13	10	16	52	0.118	0	0.856	0.036	0.033	0	50.7	48.2	74	149	142	0	31	30
2015	7	13	10	26	52	0.141	0.069	0.856	0.039	0.036	0	51.2	49.9	73.1	149	145	0	30	29
2015	7	13	10	36	52	0.112	0.052	0.86	0.033	0.03	0	52	49.9	71.4	152	147	0	31	31
2015	7	13	10	46	52	0.174	0.033	0.86	0.039	0.036	0	52.9	52	71	153	150	0	30	29
2015	7	13	10	56	52	0.184	0.023	0.856	0.036	0.033	0	52	51.6	70.5	151	150	0	30	30
2015	7	13	11	6	52	0.164	-0.026	0.86	0.033	0.03	0	52.5	53.8	71.4	153	156	0	31	31
2015	7	13	11	16	52	0.128	0.056	0.856	0.033	0.03	0	53.8	54.6	68.4	155	157	0	30	30
2015	7	13	11	26	52	0.118	0.052	0.856	0.039	0.036	0	52.9	55	70.1	153	157	0	30	29
2015	7	13	11	36	52	0.18	0.039	0.856	0.036	0.033	0	54.6	55.5	68.4	158	159	0	31	30
2015	7	13	11	46	52	0.089	0.092	0.86	0.033	0.03	0	55	56.3	67.1	158	160	0	30	29
2015	7	13	11	56	52	0.164	0.079	0.856	0.036	0.033	0	55.9	56.3	67.5	160	161	0	30	30
2015	7	13	12	6	52	0.21	0.052	0.856	0.036	0.033	0	56.3	57.2	65.8	161	163	0	30	30
2015	7	13	12	16	52	0.19	0.03	0.856	0.033	0.03	0	57.2	57.6	66.2	163	164	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	13	12	26	52	0.164	0.108	0.856	0.036	0.033	0	56.8	57.6	64.5	162	164	0	30	30
2015	7	13	12	36	52	0.131	0.036	0.856	0.036	0.033	0	57.6	57.6	65.4	165	163	0	31	29
2015	7	13	12	46	52	0.135	0.052	0.856	0.033	0.03	0	57.6	58.5	64.9	164	166	0	30	30
2015	7	13	12	56	52	0.121	0.066	0.86	0.039	0.036	0	58.5	58.5	64.5	166	165	0	30	29
2015	7	13	13	6	52	0.18	0.141	0.86	0.036	0.033	0	58.5	58	65.8	166	165	0	30	30
2015	7	13	13	16	52	0.187	0.016	0.86	0.033	0.03	0	58.9	58.5	64.5	168	166	0	31	30
2015	7	13	13	26	52	0.141	0.052	0.86	0.033	0.033	0	59.3	58.5	63.6	168	166	0	30	30
2015	7	13	13	36	52	0.138	0.082	0.86	0.033	0.03	0	59.3	58.5	62.8	168	166	0	30	30
2015	7	13	13	46	52	0.121	0.098	0.86	0.036	0.033	0	58.9	59.3	63.2	168	167	0	31	29
2015	7	13	13	56	52	0.135	0.079	0.86	0.033	0.03	0	59.8	59.3	64.1	168	167	0	29	29
2015	7	13	14	6	52	0.226	0.115	0.86	0.033	0.03	0	58.9	59.3	63.6	167	167	0	30	29
2015	7	13	14	16	52	0.194	0.043	0.86	0.033	0.03	0	59.3	59.3	62.4	168	167	0	30	29
2015	7	13	14	26	52	0.23	0.108	0.86	0.033	0.03	0	60.2	59.3	62.8	170	167	0	30	29
2015	7	13	14	36	52	0.154	0.056	0.86	0.033	0.03	0	60.6	59.3	63.2	171	168	0	30	30
2015	7	13	14	46	52	0.125	0.102	0.86	0.036	0.033	0	61.1	59.3	61.5	172	167	0	30	29
2015	7	13	14	56	52	0.157	0.125	0.86	0.036	0.033	0	61.1	59.3	61.1	172	168	0	30	30
2015	7	13	15	6	52	0.223	0.105	0.86	0.036	0.033	0	61.5	59.8	62.8	173	168	0	30	29
2015	7	13	15	16	52	0.2	0.095	0.86	0.039	0.039	0	58.5	55.9	66.7	166	159	0	30	29
2015	7	13	15	26	52	0.213	0.112	0.86	0.036	0.033	0	61.1	59.3	61.5	172	167	0	30	29
2015	7	13	15	36	52	0.23	0.059	0.86	0.033	0.03	0	60.6	58.9	62.8	170	166	0	29	29
2015	7	13	15	46	52	0.18	0.102	0.863	0.036	0.033	0	60.6	59.3	61.9	171	167	0	30	29
2015	7	13	15	56	52	0.164	0.125	0.863	0.039	0.039	0	61.1	59.3	61.5	172	167	0	30	29
2015	7	13	16	6	52	0.171	0.121	0.863	0.036	0.033	0	60.2	58.9	62.4	171	166	0	31	29
2015	7	13	16	16	52	0.102	0.056	0.863	0.043	0.039	0	61.5	58.9	62.4	173	166	0	30	29
2015	7	13	16	26	52	0.19	0.072	0.86	0.039	0.036	0	59.3	58	62.8	168	164	0	30	29
2015	7	13	16	36	52	0.164	0.075	0.863	0.039	0.036	0	59.8	58	64.9	169	164	0	30	29
2015	7	13	16	46	52	0.135	0.049	0.863	0.036	0.033	0	59.8	58.5	62.8	169	165	0	30	29
2015	7	13	16	56	52	0.164	0.102	0.863	0.039	0.036	0	58.5	56.8	64.5	167	161	0	31	29
2015	7	13	17	6	52	0.213	0.052	0.863	0.033	0.03	0	58.9	57.2	63.6	167	162	0	30	29
2015	7	13	17	16	52	0.174	0.01	0.86	0.039	0.039	0	57.6	56.3	64.1	163	160	0	29	29
2015	7	13	17	26	52	0.108	0.016	0.863	0.039	0.039	0	55	52.9	67.1	158	152	0	30	29
2015	7	13	17	36	52	0.22	-0.075	0.863	0.036	0.033	0	53.3	52.5	66.2	154	151	0	30	29
2015	7	13	17	46	52	0.121	-0.003	0.86	0.033	0.03	0	52	49.9	69.2	151	145	0	30	29
2015	7	13	17	56	52	0.157	-0.007	0.86	0.039	0.036	0	50.3	49.5	69.7	147	144	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	13	18	6	52	0.138	-0.003	0.86	0.036	0.033	0	50.3	48.6	69.2	147	142	0	30	29
2015	7	13	18	16	52	0.108	0.023	0.86	0.043	0.039	0	50.7	49	69.7	148	143	0	30	29
2015	7	13	18	26	52	0.121	-0.026	0.86	0.033	0.03	0	50.7	48.6	69.7	148	142	0	30	29
2015	7	13	18	36	52	0.154	-0.003	0.86	0.039	0.039	0	51.2	48.2	69.7	148	141	0	29	29
2015	7	13	18	46	52	0.128	-0.01	0.86	0.043	0.039	0	50.3	48.6	70.5	147	142	0	30	29
2015	7	13	18	56	52	0.174	-0.039	0.86	0.043	0.039	0	48.6	46.9	71.8	143	137	0	30	28
2015	7	13	19	6	52	0.167	-0.079	0.86	0.039	0.039	0	48.6	46.9	71.8	144	138	0	31	29
2015	7	13	19	16	52	0.171	-0.039	0.86	0.039	0.036	0	48.6	47.3	71.8	143	139	0	30	29
2015	7	13	19	26	52	0.217	0.049	0.86	0.039	0.039	0	48.6	46.4	72.2	143	137	0	30	29
2015	7	13	19	36	52	0.154	-0.033	0.86	0.043	0.039	0	51.6	50.3	68.8	150	146	0	30	29
2015	7	13	19	46	52	0.21	0.03	0.86	0.046	0.043	0	53.3	51.2	66.2	154	149	0	30	30
2015	7	13	19	56	52	0.171	-0.02	0.86	0.039	0.036	0	54.6	52.5	66.2	157	151	0	30	29
2015	7	13	20	6	52	0.194	-0.007	0.86	0.036	0.033	0	51.6	49.9	69.2	150	145	0	30	29
2015	7	13	20	16	52	0.223	-0.049	0.86	0.039	0.036	0	53.8	51.6	66.7	155	149	0	30	29
2015	7	13	20	26	52	0.187	0	0.863	0.039	0.039	0	52	50.3	68.4	151	146	0	30	29
2015	7	13	20	36	52	0.194	0.062	0.863	0.043	0.043	0	52.5	49.9	67.9	152	146	0	30	30
2015	7	13	20	46	52	0.125	0.007	0.863	0.036	0.033	0	52.9	51.6	67.1	154	149	0	31	29
2015	7	13	20	56	52	0.135	-0.039	0.863	0.036	0.033	0	55.5	53.8	64.5	159	154	0	30	29
2015	7	13	21	6	52	0.151	-0.052	0.863	0.039	0.039	0	53.8	51.6	66.7	155	149	0	30	29
2015	7	13	21	16	52	0.125	-0.079	0.86	0.039	0.036	0	52.9	51.2	66.7	153	149	0	30	30
2015	7	13	21	26	52	0.207	-0.056	0.86	0.039	0.036	0	52.5	49.9	68.4	152	145	0	30	29
2015	7	13	21	36	52	0.197	-0.102	0.863	0.039	0.036	0	51.6	49.5	69.2	150	144	0	30	29
2015	7	13	21	46	52	0.161	-0.043	0.863	0.043	0.039	0	52.5	50.7	68.4	152	147	0	30	29
2015	7	13	21	56	52	0.23	-0.059	0.863	0.039	0.039	0	50.7	49.5	69.2	149	143	0	31	28
2015	7	13	22	6	52	0.194	-0.059	0.863	0.039	0.036	0	50.7	49	69.7	148	143	0	30	29
2015	7	13	22	16	52	0.105	0.033	0.863	0.039	0.039	0	49	47.7	71.4	144	140	0	30	29
2015	7	13	22	26	52	0.167	0.016	0.863	0.039	0.036	0	46.9	45.6	73.1	139	135	0	30	29
2015	7	13	22	36	52	0.059	-0.066	0.863	0.039	0.039	0	46.9	46	73.1	139	136	0	30	29
2015	7	13	22	46	52	0.177	0.003	0.863	0.046	0.043	0	48.2	46.4	71.8	142	137	0	30	29
2015	7	13	22	56	52	0.148	-0.02	0.863	0.039	0.036	0	48.2	46.9	71	142	138	0	30	29
2015	7	13	23	6	52	0.115	0.003	0.863	0.043	0.039	0	46.9	45.6	72.7	140	136	0	31	30
2015	7	13	23	16	52	0.118	-0.079	0.863	0.039	0.036	0	46.9	45.6	73.5	139	135	0	30	29
2015	7	13	23	26	52	0.203	-0.02	0.863	0.039	0.039	0	46.4	45.2	73.1	138	134	0	30	29
2015	7	13	23	36	52	0.167	-0.01	0.863	0.033	0.03	0	46.4	44.7	73.5	138	133	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	13	23	46	52	0.131	-0.033	0.863	0.039	0.036	0	46	45.2	73.5	137	134	0	30	29
2015	7	13	23	56	52	0.213	-0.052	0.863	0.033	0.03	0	45.6	43.9	74	137	132	0	31	30
2015	7	14	0	6	52	0.217	-0.016	0.863	0.039	0.036	0	46.9	44.7	72.7	139	134	0	30	30
2015	7	14	0	16	52	0.177	-0.043	0.863	0.039	0.039	0	45.6	44.7	74	136	133	0	30	29
2015	7	14	0	26	52	0.128	0.049	0.863	0.046	0.043	0	43.9	43.4	74.8	132	130	0	30	29
2015	7	14	0	36	52	0.131	-0.036	0.863	0.039	0.036	0	43.9	43	74.4	132	130	0	30	30
2015	7	14	0	46	52	0.115	-0.072	0.863	0.039	0.036	0	45.6	44.7	73.5	136	133	0	30	29
2015	7	14	0	56	52	0.164	-0.085	0.863	0.039	0.036	0	45.6	43.9	74	136	131	0	30	29
2015	7	14	1	6	52	0.174	0.016	0.863	0.039	0.036	0	45.2	43.4	74.8	136	131	0	31	30
2015	7	14	1	16	52	0.128	-0.108	0.86	0.043	0.039	0	44.3	42.1	74.8	134	128	0	31	30
2015	7	14	1	26	52	0.141	-0.013	0.863	0.039	0.036	0	43.9	43	75.3	132	129	0	30	29
2015	7	14	1	36	52	0.164	-0.069	0.86	0.036	0.033	0	45.2	43.4	74.4	135	130	0	30	29
2015	7	14	1	46	52	0.177	-0.039	0.86	0.033	0.03	0	44.7	43	74.8	134	129	0	30	29
2015	7	14	1	56	52	0.112	-0.108	0.86	0.039	0.036	0	44.7	43	74.4	134	129	0	30	29
2015	7	14	2	6	52	0.148	-0.082	0.86	0.039	0.036	0	43.9	42.6	74.8	132	129	0	30	30
2015	7	14	2	16	52	0.167	-0.069	0.86	0.043	0.043	0	43	43.4	75.3	131	129	0	31	28
2015	7	14	2	26	52	0.118	-0.112	0.86	0.039	0.036	0	43.9	42.6	74.4	132	129	0	30	30
2015	7	14	2	36	52	0.154	-0.056	0.86	0.036	0.033	0	43.4	43	75.3	131	129	0	30	29
2015	7	14	2	46	52	0.092	-0.03	0.86	0.039	0.039	0	43.9	43	74.4	133	130	0	31	30
2015	7	14	2	56	52	0.128	-0.039	0.86	0.036	0.033	0	44.3	42.1	74.4	133	128	0	30	30
2015	7	14	3	6	52	0.089	-0.023	0.86	0.033	0.03	0	44.3	43	73.5	134	130	0	31	30
2015	7	14	3	16	52	0.151	-0.069	0.86	0.033	0.03	0	43.9	42.6	75.7	132	129	0	30	30
2015	7	14	3	26	52	0.128	0	0.86	0.043	0.039	0	44.7	43.4	74.4	135	130	0	31	29
2015	7	14	3	36	52	0.125	-0.056	0.86	0.046	0.043	0	43.4	43	74.8	132	129	0	31	29
2015	7	14	3	46	52	0.128	-0.003	0.86	0.039	0.036	0	43.4	42.1	75.3	132	128	0	31	30
2015	7	14	3	56	52	0.108	-0.108	0.86	0.039	0.039	0	43.9	42.1	75.3	132	128	0	30	30
2015	7	14	4	6	52	0.177	-0.092	0.86	0.043	0.039	0	45.2	43.9	74.4	136	132	0	31	30
2015	7	14	4	16	52	0.141	0.052	0.86	0.039	0.036	0	44.3	41.7	74.8	133	128	0	30	31
2015	7	14	4	26	52	0.105	-0.112	0.86	0.033	0.03	0	44.7	43.9	73.5	135	131	0	31	29
2015	7	14	4	36	52	0.161	-0.049	0.86	0.039	0.036	0	43.9	42.6	74.8	133	129	0	31	30
2015	7	14	4	46	52	0.089	-0.102	0.86	0.036	0.033	0	43.9	43	74.4	133	129	0	31	29
2015	7	14	4	56	52	0.125	-0.089	0.86	0.036	0.033	0	45.2	43.4	74.4	135	131	0	30	30
2015	7	14	5	6	52	0.118	-0.007	0.856	0.039	0.039	0	44.3	42.6	74.8	133	129	0	30	30
2015	7	14	5	16	52	0.174	-0.108	0.856	0.036	0.033	0	44.7	43	74.8	134	130	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	14	5	26	52	0.128	-0.046	0.856	0.039	0.036	0	43.4	42.6	75.7	131	129	0	30	30
2015	7	14	5	36	52	0.144	-0.115	0.856	0.036	0.033	0	44.3	43.4	74.4	134	130	0	31	29
2015	7	14	5	46	52	0.102	-0.036	0.856	0.036	0.033	0	45.6	43.4	74	136	130	0	30	29
2015	7	14	5	56	52	0.18	0.056	0.856	0.039	0.036	0	48.6	47.3	69.7	144	140	0	31	30
2015	7	14	6	6	52	0.151	-0.069	0.856	0.039	0.039	0	47.7	45.6	71.4	141	136	0	30	30
2015	7	14	6	16	52	0.171	-0.049	0.856	0.036	0.033	0	46.9	46	72.2	140	136	0	31	29
2015	7	14	6	26	52	0.085	-0.046	0.856	0.039	0.036	0	45.6	45.2	73.5	137	135	0	31	30
2015	7	14	6	36	52	0.056	-0.052	0.853	0.043	0.039	0	45.6	44.7	73.5	137	134	0	31	30
2015	7	14	6	46	52	0.125	-0.056	0.856	0.039	0.036	0	43.9	43	76.1	132	130	0	30	30
2015	7	14	6	56	52	0.154	-0.072	0.856	0.039	0.039	0	43.9	43	75.3	133	130	0	31	30
2015	7	14	7	6	52	0.167	-0.036	0.853	0.036	0.033	0	43.4	43	75.7	132	129	0	31	29
2015	7	14	7	16	52	0.059	-0.098	0.853	0.036	0.033	0	45.2	43.9	74.8	136	131	0	31	29
2015	7	14	7	26	52	0.105	0	0.853	0.033	0.03	0	42.6	41.3	77	129	126	0	30	30
2015	7	14	7	36	52	0.112	0.03	0.853	0.039	0.036	0	46	42.1	77	137	128	0	30	30
2015	7	14	7	46	52	0.194	0.089	0.853	0.036	0.033	0	44.7	41.3	77.4	134	126	0	30	30
2015	7	14	7	56	52	0.174	-0.007	0.853	0.043	0.039	0	43.9	43	76.5	132	130	0	30	30
2015	7	14	8	6	52	-0.072	-0.194	0.853	0.039	0.036	0	47.3	44.3	76.1	141	133	0	31	30
2015	7	14	8	16	52	-0.036	-0.266	0.853	0.036	0.033	0	49.5	44.7	75.3	146	134	0	31	30
2015	7	14	8	26	52	0.095	-0.095	0.853	0.039	0.036	0	49.5	46.9	73.5	145	139	0	30	30
2015	7	14	8	36	52	0.072	0	0.853	0.033	0.03	0	50.7	47.3	75.3	149	139	0	31	29
2015	7	14	8	46	52	0.144	-0.049	0.85	0.033	0.03	0	49.9	49	72.2	147	144	0	31	30
2015	7	14	8	56	52	0.203	0.075	0.85	0.033	0.03	0	49	47.7	73.5	144	141	0	30	30
2015	7	14	9	6	52	0.154	-0.02	0.85	0.039	0.036	0	49.9	48.2	72.2	147	142	0	31	30
2015	7	14	9	16	52	0.108	-0.092	0.85	0.03	0.03	0	51.2	49.5	72.2	150	144	0	31	29
2015	7	14	9	26	52	0.072	0	0.85	0.033	0.03	0	49	49.5	71	145	145	0	31	30
2015	7	14	9	36	52	0.112	0.016	0.85	0.036	0.033	0	49.9	49.9	71.4	147	146	0	31	30
2015	7	14	9	46	52	0.135	-0.023	0.85	0.033	0.03	0	50.7	49	72.2	149	143	0	31	29
2015	7	14	9	56	52	0.089	-0.039	0.846	0.033	0.03	0	52.5	49.9	68.4	153	146	0	31	30
2015	7	14	10	6	52	0.092	-0.043	0.85	0.039	0.039	0	52.9	51.2	68.4	154	148	0	31	29
2015	7	14	10	16	52	0.144	0.105	0.846	0.033	0.03	0	56.3	54.2	63.6	161	156	0	30	30
2015	7	14	10	26	52	0.135	0.092	0.846	0.036	0.033	0	54.2	52	66.2	156	151	0	30	30
2015	7	14	10	36	52	0.167	0.089	0.846	0.039	0.036	0	53.8	51.2	67.9	156	148	0	31	29
2015	7	14	10	46	52	-0.02	-0.046	0.846	0.036	0.033	0	55	51.6	67.9	158	150	0	30	30
2015	7	14	10	56	52	0.207	0.02	0.843	0.033	0.03	0	52.5	52.5	67.1	152	152	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	14	11	6	52	0.148	-0.105	0.843	0.036	0.033	0	52.9	52.9	67.9	154	152	0	31	29
2015	7	14	11	16	52	0.098	0.082	0.84	0.033	0.03	0	55	52.9	67.1	158	153	0	30	30
2015	7	14	11	26	52	0.18	0.046	0.84	0.033	0.03	0	55.5	54.6	67.1	159	156	0	30	29
2015	7	14	11	36	52	0.036	-0.023	0.837	0.033	0.03	0	54.6	54.2	66.2	157	156	0	30	30
2015	7	14	11	46	52	0.089	0.016	0.833	0.039	0.036	0	54.6	55.5	65.4	157	159	0	30	30
2015	7	14	11	56	52	0.105	0.026	0.83	0.036	0.033	0	55	55	65.4	158	158	0	30	30
2015	7	14	12	6	52	0.148	0.089	0.83	0.036	0.033	0	54.2	56.3	65.4	157	160	0	31	29
2015	7	14	12	16	52	0.144	0.066	0.83	0.033	0.03	0	55	56.3	64.1	159	161	0	31	30
2015	7	14	12	26	52	0.131	0.036	0.827	0.046	0.043	0	55.9	56.8	64.9	160	162	0	30	30
2015	7	14	12	36	52	0.171	0.056	0.827	0.033	0.03	0	55	57.2	63.6	159	163	0	31	30
2015	7	14	12	46	52	0.167	0.01	0.827	0.033	0.03	0	57.2	57.2	64.1	163	163	0	30	30
2015	7	14	12	56	52	0.18	0.092	0.827	0.043	0.039	0	57.2	57.6	64.9	163	164	0	30	30
2015	7	14	13	6	52	0.128	0.003	0.823	0.033	0.03	0	57.2	58	65.8	163	164	0	30	29
2015	7	14	13	16	52	0.092	0.092	0.827	0.033	0.03	0	57.6	58	64.9	165	164	0	31	29
2015	7	14	13	26	52	0.19	0.092	0.827	0.036	0.033	0	58	58.9	64.1	165	166	0	30	29
2015	7	14	13	36	52	0.151	0.039	0.823	0.039	0.036	0	58.9	58	63.6	167	164	0	30	29
2015	7	14	13	46	52	0.141	0.131	0.823	0.039	0.036	0	58.5	58.9	64.1	166	166	0	30	29
2015	7	14	13	56	52	0.135	0.046	0.823	0.033	0.03	0	58.5	58.5	64.5	166	166	0	30	30
2015	7	14	14	6	52	0.112	0	0.823	0.039	0.039	0	58.5	58.5	64.9	166	165	0	30	29
2015	7	14	14	16	52	0.059	0.059	0.823	0.033	0.03	0	58.9	58.9	62.8	167	166	0	30	29
2015	7	14	14	26	52	0.131	0.036	0.823	0.036	0.033	0	58.9	59.3	62.4	167	167	0	30	29
2015	7	14	14	36	52	0.148	0.092	0.823	0.036	0.033	0	60.2	58.5	63.2	170	165	0	30	29
2015	7	14	14	46	52	0.105	0.056	0.823	0.036	0.033	0	60.2	58.9	62.8	170	166	0	30	29
2015	7	14	14	56	52	0.154	0.023	0.823	0.033	0.03	0	59.8	59.3	63.6	169	167	0	30	29
2015	7	14	15	6	52	0.102	0.069	0.823	0.039	0.036	0	60.2	59.3	61.5	169	167	0	29	29
2015	7	14	15	16	52	0.151	0.056	0.823	0.036	0.033	0	60.6	59.3	60.2	170	167	0	29	29
2015	7	14	15	26	52	0.072	0.03	0.823	0.033	0.03	0	58	57.2	65.8	165	162	0	30	29
2015	7	14	15	36	52	0.174	0.085	0.823	0.033	0.03	0	59.3	58.9	64.5	168	166	0	30	29
2015	7	14	15	46	52	0.118	0.118	0.823	0.036	0.033	0	59.8	59.8	64.5	169	168	0	30	29
2015	7	14	15	56	52	0.157	0.023	0.823	0.036	0.033	0	59.3	58.9	64.9	168	166	0	30	29
2015	7	14	16	6	52	0.151	0.128	0.823	0.036	0.033	0	59.3	58.9	64.5	168	166	0	30	29
2015	7	14	16	16	52	0.213	0.108	0.82	0.036	0.033	0	59.8	58.5	64.9	169	165	0	30	29
2015	7	14	16	26	52	0.135	0.115	0.82	0.036	0.033	0	59.3	58.5	64.1	168	165	0	30	29
2015	7	14	16	36	52	0.135	0.095	0.82	0.036	0.033	0	60.2	58	64.9	170	164	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	14	16	46	52	0.19	0.102	0.82	0.039	0.036	0	58.5	57.6	64.5	166	163	0	30	29
2015	7	14	16	56	52	0.115	0.043	0.82	0.033	0.03	0	57.6	57.6	65.8	165	163	0	31	29
2015	7	14	17	6	52	0.079	0.069	0.82	0.036	0.033	0	58	57.2	65.8	165	161	0	30	28
2015	7	14	17	16	52	0.135	0.062	0.82	0.033	0.03	0	57.6	56.8	65.4	164	161	0	30	29
2015	7	14	17	26	52	0.187	-0.03	0.817	0.036	0.033	0	55.9	55.5	66.7	160	158	0	30	29
2015	7	14	17	36	52	0.125	0.052	0.82	0.036	0.033	0	53.8	53.8	68.4	155	154	0	30	29
2015	7	14	17	46	52	0.171	0.072	0.817	0.039	0.036	0	50.7	50.7	70.5	148	147	0	30	29
2015	7	14	17	56	52	0.144	0.121	0.817	0.033	0.03	0	52.5	51.6	67.5	152	149	0	30	29
2015	7	14	18	6	52	0.151	0.095	0.817	0.043	0.039	0	50.7	49.9	68.8	148	145	0	30	29
2015	7	14	18	16	52	0.135	0.095	0.817	0.039	0.036	0	49	47.7	70.5	144	140	0	30	29
2015	7	14	18	26	52	0.079	0.079	0.817	0.039	0.036	0	46.4	45.6	72.2	138	135	0	30	29
2015	7	14	18	36	52	0.095	0.135	0.817	0.033	0.03	0	46	44.7	72.7	137	133	0	30	29
2015	7	14	18	46	52	0.144	0.128	0.817	0.039	0.036	0	44.7	43.9	73.5	134	131	0	30	29
2015	7	14	18	56	52	0.144	0.105	0.817	0.039	0.036	0	44.3	43.4	73.5	133	130	0	30	29
2015	7	14	19	6	52	0.141	0.092	0.814	0.043	0.039	0	45.2	44.3	72.7	135	132	0	30	29
2015	7	14	19	16	52	0.089	0.043	0.814	0.033	0.03	0	44.3	43.4	73.1	133	130	0	30	29
2015	7	14	19	26	52	0.069	-0.007	0.814	0.039	0.036	0	44.7	44.3	72.7	134	132	0	30	29
2015	7	14	19	36	52	0.092	0.036	0.814	0.039	0.039	0	45.2	43.9	72.7	135	131	0	30	29
2015	7	14	19	46	52	0.141	-0.059	0.814	0.043	0.043	0	44.7	43.9	72.7	134	131	0	30	29
2015	7	14	19	56	52	0.131	0.023	0.814	0.039	0.036	0	45.6	43.4	72.2	135	130	0	29	29
2015	7	14	20	6	52	0.089	-0.016	0.814	0.049	0.046	0	46.9	45.6	71	139	135	0	30	29
2015	7	14	20	16	52	0.174	0.03	0.814	0.036	0.033	0	47.3	45.6	70.5	140	135	0	30	29
2015	7	14	20	26	52	0.19	0.02	0.81	0.046	0.043	0	49.9	48.2	67.9	146	141	0	30	29
2015	7	14	20	36	52	0.069	-0.03	0.81	0.039	0.039	0	48.6	46.4	69.7	143	137	0	30	29
2015	7	14	20	46	52	0.115	0.026	0.814	0.033	0.03	0	46.9	45.2	70.1	139	134	0	30	29
2015	7	14	20	56	52	0.157	-0.02	0.81	0.039	0.039	0	45.6	44.3	70.5	136	132	0	30	29
2015	7	14	21	6	52	0.056	0.01	0.814	0.036	0.033	0	46	44.3	71.8	137	133	0	30	30
2015	7	14	21	16	52	0.049	-0.043	0.814	0.039	0.036	0	45.6	44.3	71.8	136	132	0	30	29
2015	7	14	21	26	52	0.125	0.036	0.814	0.039	0.036	0	45.6	44.3	71.8	135	132	0	29	29
2015	7	14	21	36	52	0.115	0	0.81	0.039	0.036	0	48.2	46.4	68.8	142	138	0	30	30
2015	7	14	21	46	52	0.118	-0.069	0.81	0.043	0.039	0	54.2	52.5	62.4	156	151	0	30	29
2015	7	14	21	56	52	0.18	-0.056	0.81	0.039	0.039	0	51.2	49.9	64.9	149	145	0	30	29
2015	7	14	22	6	52	0.177	0.003	0.81	0.039	0.036	0	47.7	46.4	70.1	141	137	0	30	29
2015	7	14	22	16	52	0.108	0.023	0.81	0.036	0.033	0	47.7	46	68.8	141	137	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	14	22	26	52	0.095	-0.026	0.81	0.036	0.033	0	46	44.3	70.5	137	133	0	30	30
2015	7	14	22	36	52	0.085	-0.046	0.81	0.039	0.036	0	45.6	44.7	71.4	136	133	0	30	29
2015	7	14	22	46	52	0.102	-0.023	0.81	0.049	0.046	0	43.4	43.4	71.8	131	130	0	30	29
2015	7	14	22	56	52	0.105	-0.066	0.81	0.039	0.039	0	44.3	43.4	72.7	133	130	0	30	29
2015	7	14	23	6	52	0.154	-0.039	0.81	0.039	0.036	0	44.7	43.9	71.4	134	131	0	30	29
2015	7	14	23	16	52	0.135	0	0.807	0.039	0.036	0	43.4	43.9	71	132	131	0	31	29
2015	7	14	23	26	52	0.095	0	0.807	0.036	0.033	0	43.9	43.4	71.4	132	130	0	30	29
2015	7	14	23	36	52	0.115	-0.066	0.807	0.043	0.039	0	44.3	43.4	70.5	133	131	0	30	30
2015	7	14	23	46	52	0.089	0.036	0.804	0.036	0.033	0	44.3	42.1	70.1	133	128	0	30	30
2015	7	14	23	56	52	0.089	0.043	0.804	0.039	0.036	0	43.9	43.4	71.4	132	130	0	30	29
2015	7	15	0	6	52	0.069	-0.039	0.807	0.033	0.03	0	43.9	43.4	71.8	132	130	0	30	29
2015	7	15	0	16	52	0.154	-0.02	0.804	0.039	0.036	0	44.3	43	71	132	129	0	29	29
2015	7	15	0	26	52	0.089	0.01	0.804	0.039	0.036	0	43.9	43.4	71	132	130	0	30	29
2015	7	15	0	36	52	0.089	0.036	0.801	0.036	0.033	0	43.9	43	71	132	129	0	30	29
2015	7	15	0	46	52	0.125	-0.013	0.797	0.033	0.03	0	42.6	43.4	71	129	130	0	30	29
2015	7	15	0	56	52	0.151	-0.003	0.794	0.039	0.036	0	43.9	43	71	132	129	0	30	29
2015	7	15	1	6	52	0.151	-0.033	0.794	0.036	0.033	0	44.3	43	71	133	129	0	30	29
2015	7	15	1	16	52	0.112	-0.066	0.794	0.039	0.036	0	46.4	46	69.2	138	136	0	30	29
2015	7	15	1	26	52	0.075	-0.043	0.794	0.036	0.033	0	46.4	45.2	69.2	138	135	0	30	30
2015	7	15	1	36	52	0.039	-0.007	0.794	0.033	0.03	0	46	45.2	69.2	137	134	0	30	29
2015	7	15	1	46	52	0.098	0.003	0.794	0.036	0.033	0	43.4	43	70.5	131	129	0	30	29
2015	7	15	1	56	52	0.105	0.016	0.791	0.039	0.036	0	48.2	46	68.4	142	136	0	30	29
2015	7	15	2	6	52	0.075	0.003	0.791	0.036	0.033	0	43.9	43	71.8	132	130	0	30	30
2015	7	15	2	16	52	0.148	-0.016	0.791	0.046	0.043	0	44.7	43.4	71.4	134	131	0	30	30
2015	7	15	2	26	52	0.079	0	0.791	0.039	0.036	0	43.4	43.9	71	132	131	0	31	29
2015	7	15	2	36	52	0.082	-0.072	0.791	0.043	0.039	0	43.9	43.9	71.4	132	131	0	30	29
2015	7	15	2	46	52	0.052	-0.02	0.791	0.036	0.033	0	45.6	44.7	70.1	137	133	0	31	29
2015	7	15	2	56	52	0.108	0.036	0.787	0.043	0.039	0	45.2	43.9	71	135	132	0	30	30
2015	7	15	3	6	52	0.154	-0.003	0.787	0.039	0.036	0	46.4	45.6	69.7	138	135	0	30	29
2015	7	15	3	16	52	0.098	-0.026	0.787	0.039	0.039	0	43.9	43.9	71.8	133	131	0	31	29
2015	7	15	3	26	52	0.085	-0.013	0.787	0.039	0.039	0	46.9	46	69.7	139	137	0	30	30
2015	7	15	3	36	52	0.085	-0.039	0.787	0.036	0.033	0	47.7	46.4	67.9	142	138	0	31	30
2015	7	15	3	46	52	0.079	0.016	0.787	0.039	0.039	0	43	42.6	72.2	131	129	0	31	30
2015	7	15	3	56	52	0.125	0.007	0.787	0.033	0.03	0	43	42.6	72.2	130	129	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	15	4	6	52	0.089	0.007	0.787	0.039	0.036	0	43.4	43.4	72.2	131	131	0	30	30
2015	7	15	4	16	52	0.184	-0.023	0.784	0.039	0.036	0	46	45.6	70.1	138	135	0	31	29
2015	7	15	4	26	52	0.128	-0.007	0.784	0.039	0.036	0	47.3	46	69.2	140	136	0	30	29
2015	7	15	4	36	52	0.125	0	0.787	0.039	0.036	0	43.4	42.6	71.8	132	129	0	31	30
2015	7	15	4	46	52	0.069	-0.036	0.787	0.036	0.033	0	43.9	43.4	71.8	133	131	0	31	30
2015	7	15	4	56	52	0.052	0.016	0.787	0.039	0.039	0	45.2	44.3	71	135	133	0	30	30
2015	7	15	5	6	52	0	-0.062	0.787	0.039	0.039	0	44.3	43.4	71.4	133	131	0	30	30
2015	7	15	5	16	52	0.164	-0.092	0.787	0.036	0.033	0	42.6	42.6	72.2	130	128	0	31	29
2015	7	15	5	26	52	0.125	-0.039	0.787	0.033	0.03	0	43	43.4	71.4	131	131	0	31	30
2015	7	15	5	36	52	0.023	-0.02	0.787	0.036	0.033	0	42.6	41.7	71.4	130	127	0	31	30
2015	7	15	5	46	52	0.171	-0.036	0.787	0.036	0.033	0	43	42.6	71.8	130	128	0	30	29
2015	7	15	5	56	52	0.112	-0.02	0.791	0.039	0.036	0	46.4	45.6	68.8	139	136	0	31	30
2015	7	15	6	6	52	0.049	-0.02	0.791	0.039	0.039	0	48.6	46.4	67.5	143	138	0	30	30
2015	7	15	6	16	52	0.075	-0.089	0.797	0.039	0.036	0	43.4	43	71	131	130	0	30	30
2015	7	15	6	26	52	0.102	-0.075	0.797	0.043	0.039	0	45.6	43.9	68.8	136	132	0	30	30
2015	7	15	6	36	52	0.069	0.033	0.801	0.036	0.033	0	41.3	41.3	71.4	127	126	0	31	30
2015	7	15	6	46	52	0.105	-0.066	0.801	0.039	0.036	0	43.4	42.6	70.5	132	129	0	31	30
2015	7	15	6	56	52	0.167	-0.062	0.801	0.036	0.033	0	43	42.6	71	131	130	0	31	31
2015	7	15	7	6	52	0.089	0.036	0.801	0.043	0.043	0	45.6	43.9	71	137	132	0	31	30
2015	7	15	7	16	52	0.105	0.007	0.804	0.039	0.036	0	44.3	43	71	133	130	0	30	30
2015	7	15	7	26	52	0.092	-0.082	0.804	0.039	0.036	0	44.7	43.4	70.5	135	131	0	31	30
2015	7	15	7	36	52	0.151	0.039	0.804	0.039	0.039	0	43.4	41.7	74	131	126	0	30	29
2015	7	15	7	46	52	0.033	0	0.807	0.033	0.03	0	43.9	42.6	74	133	128	0	31	29
2015	7	15	7	56	52	0.164	0.01	0.807	0.039	0.039	0	44.7	43	72.7	136	130	0	32	30
2015	7	15	8	6	52	0.171	0.082	0.81	0.033	0.03	0	47.7	44.3	74	141	132	0	30	29
2015	7	15	8	16	52	0.013	-0.125	0.807	0.033	0.03	0	48.2	45.6	72.7	143	136	0	31	30
2015	7	15	8	26	52	0.039	-0.085	0.81	0.039	0.039	0	48.2	46.9	71.8	142	139	0	30	30
2015	7	15	8	36	52	0.115	-0.016	0.81	0.036	0.033	0	50.3	49	71.4	147	144	0	30	30
2015	7	15	8	46	52	0.072	0	0.81	0.043	0.039	0	62.4	59.3	52.5	175	168	0	30	30
2015	7	15	8	56	52	0.089	-0.043	0.817	0.036	0.033	0	49	49	71.8	145	144	0	31	30
2015	7	15	9	6	52	0.079	-0.023	0.817	0.036	0.033	0	50.3	49.5	73.5	147	145	0	30	30
2015	7	15	9	16	52	0.115	0.003	0.817	0.033	0.03	0	49	48.2	73.5	145	142	0	31	30
2015	7	15	9	26	52	0.144	-0.072	0.817	0.033	0.03	0	48.6	49	71.8	144	144	0	31	30
2015	7	15	9	36	52	0.18	0.052	0.817	0.036	0.033	0	48.6	47.3	73.1	144	141	0	31	31

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	15	9	46	52	0.171	0.016	0.817	0.033	0.03	0	48.6	48.2	74.4	143	142	0	30	30
2015	7	15	9	56	52	0.115	0.02	0.817	0.033	0.033	0	48.6	48.2	74.4	143	142	0	30	30
2015	7	15	10	6	52	0.095	0	0.817	0.033	0.03	0	47.3	47.3	74.4	141	140	0	31	30
2015	7	15	10	16	52	0.066	-0.02	0.817	0.039	0.036	0	47.7	47.7	74	141	141	0	30	30
2015	7	15	10	26	52	0.128	0.013	0.817	0.033	0.03	0	48.2	47.3	74.4	142	140	0	30	30
2015	7	15	10	36	52	0.112	0.023	0.817	0.033	0.03	0	46.9	47.3	73.1	140	140	0	31	30
2015	7	15	10	46	52	0.089	0.043	0.817	0.033	0.03	0	48.2	49	73.5	142	143	0	30	29
2015	7	15	10	56	52	0.112	0.016	0.817	0.033	0.03	0	49	48.6	73.1	144	143	0	30	30
2015	7	15	11	6	52	0.059	0.016	0.82	0.033	0.03	0	49	49	73.5	144	144	0	30	30
2015	7	15	11	16	52	0.125	0.013	0.82	0.033	0.03	0	48.6	48.6	72.7	144	143	0	31	30
2015	7	15	11	26	52	0.105	-0.033	0.82	0.039	0.036	0	49	49	71.8	145	144	0	31	30
2015	7	15	11	36	52	0.161	0.01	0.82	0.033	0.03	0	49.5	49.9	72.2	146	146	0	31	30
2015	7	15	11	46	52	0.128	0	0.82	0.036	0.033	0	51.2	50.7	71.8	148	148	0	29	30
2015	7	15	11	56	52	0.138	-0.098	0.82	0.036	0.033	0	49.5	49.9	71.4	145	146	0	30	30
2015	7	15	12	6	52	0.079	0	0.82	0.033	0.03	0	51.6	50.3	70.5	150	147	0	30	30
2015	7	15	12	16	52	0.085	0.046	0.82	0.036	0.033	0	51.6	51.6	69.7	151	149	0	31	29
2015	7	15	12	26	52	0.115	0.01	0.82	0.039	0.036	0	51.6	52.5	70.1	151	151	0	31	29
2015	7	15	12	36	52	0.128	0	0.82	0.033	0.03	0	51.2	51.2	68.8	149	149	0	30	30
2015	7	15	12	46	52	0.203	0.039	0.823	0.033	0.03	0	52	52.5	69.7	151	151	0	30	29
2015	7	15	12	56	52	0.171	0.043	0.823	0.033	0.03	0	52.5	51.2	69.7	152	149	0	30	30
2015	7	15	13	6	52	0.177	0	0.823	0.033	0.03	0	53.3	52.9	68.4	154	152	0	30	29
2015	7	15	13	16	52	0.151	0.112	0.827	0.039	0.036	0	52.9	53.3	69.7	154	153	0	31	29
2015	7	15	13	26	52	0.082	0.075	0.827	0.039	0.036	0	53.8	53.8	67.5	155	154	0	30	29
2015	7	15	13	36	52	0.118	-0.036	0.827	0.036	0.033	0	54.6	53.3	67.5	157	154	0	30	30
2015	7	15	13	46	52	0.148	0.062	0.83	0.036	0.033	0	55	54.2	66.2	158	155	0	30	29
2015	7	15	13	56	52	0.095	0.092	0.83	0.039	0.039	0	53.8	52.9	66.7	155	153	0	30	30
2015	7	15	14	6	52	0.135	0.062	0.83	0.033	0.03	0	54.6	54.6	67.1	157	156	0	30	29
2015	7	15	14	16	52	0.167	0.003	0.833	0.036	0.033	0	54.6	53.8	65.8	157	154	0	30	29
2015	7	15	14	26	52	0.157	0.023	0.833	0.033	0.03	0	55	54.6	65.4	159	156	0	31	29
2015	7	15	14	36	52	0.177	0.059	0.837	0.039	0.036	0	55	54.6	65.4	158	156	0	30	29
2015	7	15	14	46	52	0.128	0.095	0.837	0.033	0.03	0	56.3	54.6	64.1	161	156	0	30	29
2015	7	15	14	56	52	0.121	0.098	0.837	0.036	0.033	0	57.2	55	62.8	163	157	0	30	29
2015	7	15	15	6	52	0.249	0.072	0.837	0.036	0.033	0	55.5	55	63.2	160	157	0	31	29
2015	7	15	15	16	52	0.151	0.112	0.84	0.036	0.033	0	55.9	54.6	64.1	160	156	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	15	15	26	52	0.157	0.102	0.84	0.03	0.03	0	53.8	54.6	66.7	155	156	0	30	29
2015	7	15	15	36	52	0.194	0.095	0.846	0.039	0.036	0	54.2	54.6	65.8	156	156	0	30	29
2015	7	15	15	46	52	0.108	0.039	0.846	0.033	0.03	0	54.2	54.2	66.2	157	155	0	31	29
2015	7	15	15	56	52	0.151	0.056	0.846	0.036	0.033	0	54.6	54.2	66.7	156	155	0	29	29
2015	7	15	16	6	52	0.148	0.039	0.85	0.033	0.03	0	54.2	53.8	66.7	156	153	0	30	28
2015	7	15	16	16	52	0.194	0.036	0.85	0.033	0.03	0	53.8	53.3	65.4	155	153	0	30	29
2015	7	15	16	26	52	0.125	0.108	0.85	0.033	0.03	0	53.3	52.9	66.2	154	152	0	30	29
2015	7	15	16	36	52	0.135	0.023	0.85	0.039	0.036	0	52.9	52.9	64.9	153	152	0	30	29
2015	7	15	16	46	52	0.174	0.036	0.853	0.033	0.03	0	52.9	52	67.1	153	150	0	30	29
2015	7	15	16	56	52	0.138	0.089	0.853	0.033	0.03	0	52.9	52.9	67.5	153	151	0	30	28
2015	7	15	17	6	52	0.138	0.075	0.853	0.039	0.036	0	52.5	51.6	66.7	152	150	0	30	30
2015	7	15	17	16	52	0.157	-0.013	0.853	0.033	0.03	0	53.3	51.6	68.4	154	149	0	30	29
2015	7	15	17	26	52	0.177	-0.056	0.856	0.033	0.03	0	52	51.2	68.8	150	148	0	29	29
2015	7	15	17	36	52	0.135	0.118	0.856	0.033	0.03	0	53.3	51.2	66.7	153	148	0	29	29
2015	7	15	17	46	52	0.177	0.108	0.856	0.043	0.039	0	48.2	46.9	72.2	141	138	0	29	29
2015	7	15	17	56	52	0.253	0.039	0.856	0.039	0.036	0	45.2	44.7	73.1	135	133	0	30	29
2015	7	15	18	6	52	0.177	-0.01	0.86	0.036	0.033	0	47.3	46.9	73.1	140	138	0	30	29
2015	7	15	18	16	52	0.203	-0.02	0.86	0.033	0.03	0	45.6	45.2	74.4	136	134	0	30	29
2015	7	15	18	26	52	0.171	0.046	0.86	0.039	0.039	0	45.6	44.7	73.5	136	132	0	30	28
2015	7	15	18	36	52	0.144	-0.072	0.86	0.033	0.03	0	45.6	44.7	74	136	133	0	30	29
2015	7	15	18	46	52	0.21	0.039	0.86	0.039	0.036	0	47.3	45.6	72.7	140	135	0	30	29
2015	7	15	18	56	52	0.138	-0.02	0.863	0.039	0.039	0	49	47.3	72.2	144	139	0	30	29
2015	7	15	19	6	52	0.079	-0.069	0.863	0.036	0.033	0	47.3	44.7	73.5	139	133	0	29	29
2015	7	15	19	16	52	0.194	0.007	0.863	0.039	0.036	0	50.3	48.6	70.5	147	141	0	30	28
2015	7	15	19	26	52	0.131	0.036	0.863	0.039	0.039	0	49.5	46.9	71	145	138	0	30	29
2015	7	15	19	36	52	0.131	-0.039	0.863	0.036	0.033	0	54.2	52	66.7	156	150	0	30	29
2015	7	15	19	46	52	0.108	-0.023	0.863	0.039	0.036	0	49.9	47.7	71	145	140	0	29	29
2015	7	15	19	56	52	0.177	0.02	0.863	0.036	0.033	0	49	47.3	71	144	139	0	30	29
2015	7	15	20	6	52	0.138	0.016	0.863	0.039	0.039	0	48.6	46	72.2	142	136	0	29	29
2015	7	15	20	16	52	0.151	-0.003	0.863	0.039	0.036	0	47.3	46	72.2	140	136	0	30	29
2015	7	15	20	26	52	0.187	-0.102	0.863	0.043	0.039	0	49	47.3	70.1	144	139	0	30	29
2015	7	15	20	36	52	0.23	-0.069	0.866	0.039	0.039	0	48.2	46.4	71	142	137	0	30	29
2015	7	15	20	46	52	0.131	-0.085	0.866	0.039	0.036	0	48.6	46.9	71	143	138	0	30	29
2015	7	15	20	56	52	0.177	0.02	0.866	0.043	0.039	0	51.2	49	68.8	149	142	0	30	28

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	15	21	6	52	0.167	-0.056	0.866	0.036	0.033	0	49.9	48.2	68.8	146	141	0	30	29
2015	7	15	21	16	52	0.19	-0.016	0.866	0.036	0.033	0	49.9	48.2	68.4	145	141	0	29	29
2015	7	15	21	26	52	0.167	-0.056	0.866	0.039	0.039	0	47.3	46	71	140	136	0	30	29
2015	7	15	21	36	52	0.174	-0.046	0.866	0.046	0.043	0	47.3	46.4	71	140	137	0	30	29
2015	7	15	21	46	52	0.213	-0.039	0.866	0.033	0.03	0	49.5	47.7	69.2	145	140	0	30	29
2015	7	15	21	56	52	0.184	-0.056	0.866	0.039	0.036	0	49.9	48.2	68.8	146	141	0	30	29
2015	7	15	22	6	52	0.194	0.026	0.866	0.036	0.033	0	48.2	46.9	71	142	138	0	30	29
2015	7	15	22	16	52	0.151	-0.03	0.866	0.036	0.033	0	49.5	48.2	68.8	145	141	0	30	29
2015	7	15	22	26	52	0.108	0	0.866	0.039	0.036	0	52.9	50.7	66.7	153	147	0	30	29
2015	7	15	22	36	52	0.135	0.013	0.866	0.039	0.036	0	49.9	47.7	67.9	146	140	0	30	29
2015	7	15	22	46	52	0.174	0.03	0.869	0.036	0.033	0	50.3	48.2	67.9	147	142	0	30	30
2015	7	15	22	56	52	0.154	-0.026	0.869	0.039	0.036	0	51.2	49	67.1	149	143	0	30	29
2015	7	15	23	6	52	0.197	-0.007	0.869	0.036	0.033	0	47.3	45.6	70.5	140	136	0	30	30
2015	7	15	23	16	52	0.174	0.079	0.869	0.039	0.036	0	46.9	45.6	69.7	139	135	0	30	29
2015	7	15	23	26	52	0.21	-0.01	0.869	0.039	0.039	0	51.6	49.9	66.7	150	145	0	30	29
2015	7	15	23	36	52	0.115	0.036	0.869	0.039	0.039	0	48.2	46.4	68.4	142	138	0	30	30
2015	7	15	23	46	52	0.167	-0.016	0.873	0.039	0.036	0	45.2	44.7	71	136	133	0	31	29
2015	7	15	23	56	52	0.203	-0.007	0.873	0.039	0.036	0	45.6	44.7	71	136	133	0	30	29
2015	7	16	0	6	52	0.207	0.046	0.873	0.039	0.039	0	43.9	44.3	72.2	132	132	0	30	29
2015	7	16	0	16	52	0.2	0.016	0.873	0.036	0.033	0	44.7	43.4	71.4	134	131	0	30	30
2015	7	16	0	26	52	0.197	-0.023	0.876	0.046	0.046	0	44.3	43.4	71.4	134	130	0	31	29
2015	7	16	0	36	52	0.19	-0.007	0.879	0.039	0.039	0	43.9	42.6	71.8	132	128	0	30	29
2015	7	16	0	46	52	0.18	-0.075	0.879	0.043	0.039	0	42.6	42.6	71.4	130	128	0	31	29
2015	7	16	0	56	52	0.151	0.023	0.879	0.036	0.033	0	44.7	43	72.2	134	130	0	30	30
2015	7	16	1	6	52	0.157	0.016	0.879	0.039	0.036	0	44.3	43.4	71.4	133	131	0	30	30
2015	7	16	1	16	52	0.187	-0.023	0.879	0.039	0.036	0	43.4	42.6	72.7	132	129	0	31	30
2015	7	16	1	26	52	0.121	0.033	0.883	0.036	0.033	0	43.9	43.4	72.2	132	130	0	30	29
2015	7	16	1	36	52	0.18	-0.079	0.883	0.036	0.033	0	43	42.6	72.7	131	129	0	31	30
2015	7	16	1	46	52	0.207	0.03	0.883	0.033	0.03	0	42.6	42.6	72.7	130	128	0	31	29
2015	7	16	1	56	52	0.299	0.003	0.883	0.036	0.033	0	43.9	43.9	71.8	132	131	0	30	29
2015	7	16	2	6	52	0.203	-0.072	0.883	0.039	0.039	0	43.9	43	72.2	132	130	0	30	30
2015	7	16	2	16	52	0.243	-0.066	0.883	0.033	0.03	0	43.4	42.6	73.1	131	129	0	30	30
2015	7	16	2	26	52	0.24	0.003	0.883	0.043	0.039	0	50.7	49	66.2	149	143	0	31	29
2015	7	16	2	36	52	0.22	-0.062	0.883	0.043	0.039	0	51.6	49.9	66.2	151	146	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	16	2	46	52	0.167	-0.092	0.886	0.046	0.043	0	44.3	43.4	72.7	134	130	0	31	29
2015	7	16	2	56	52	0.128	-0.049	0.883	0.052	0.049	0	53.8	51.2	64.1	154	149	0	29	30
2015	7	16	3	6	52	0.167	0.01	0.883	0.039	0.036	0	45.6	45.2	71	137	134	0	31	29
2015	7	16	3	16	52	0.203	-0.069	0.886	0.039	0.036	0	44.7	43	72.7	134	130	0	30	30
2015	7	16	3	26	52	0.24	0.016	0.883	0.039	0.036	0	45.2	44.3	72.2	135	132	0	30	29
2015	7	16	3	36	52	0.148	-0.036	0.886	0.049	0.046	0	44.7	43.4	72.2	134	130	0	30	29
2015	7	16	3	46	52	0.157	-0.069	0.886	0.039	0.036	0	44.3	42.6	73.1	133	129	0	30	30
2015	7	16	3	56	52	0.194	0.026	0.886	0.039	0.036	0	44.3	43	73.1	134	130	0	31	30
2015	7	16	4	6	52	0.115	0.016	0.886	0.036	0.033	0	44.7	43.9	72.7	134	131	0	30	29
2015	7	16	4	16	52	0.236	-0.023	0.886	0.039	0.039	0	44.3	43.9	72.7	133	131	0	30	29
2015	7	16	4	26	52	0.138	-0.033	0.886	0.039	0.036	0	45.2	44.7	71.8	135	133	0	30	29
2015	7	16	4	36	52	0.213	0.056	0.886	0.039	0.039	0	43.9	43.4	72.7	133	131	0	31	30
2015	7	16	4	46	52	0.177	-0.01	0.886	0.036	0.033	0	43.4	43.4	73.1	132	131	0	31	30
2015	7	16	4	56	52	0.154	0.026	0.886	0.033	0.03	0	43.9	43.4	72.7	132	130	0	30	29
2015	7	16	5	6	52	0.233	0.033	0.886	0.039	0.036	0	43.9	43.9	72.7	132	131	0	30	29
2015	7	16	5	16	52	0.177	-0.016	0.886	0.039	0.036	0	44.3	43.9	73.5	134	132	0	31	30
2015	7	16	5	26	52	0.2	-0.056	0.886	0.039	0.036	0	46.4	46	71	138	136	0	30	29
2015	7	16	5	36	52	0.121	-0.01	0.886	0.039	0.039	0	44.3	42.6	72.7	134	129	0	31	30
2015	7	16	5	46	52	0.217	-0.01	0.886	0.033	0.03	0	45.2	43.9	73.1	135	131	0	30	29
2015	7	16	5	56	52	0.213	-0.036	0.886	0.039	0.036	0	44.3	43	73.1	134	130	0	31	30
2015	7	16	6	6	52	0.187	-0.033	0.886	0.036	0.033	0	43	42.1	75.3	130	128	0	30	30
2015	7	16	6	16	52	0.217	0.01	0.886	0.039	0.039	0	48.6	47.7	70.1	144	141	0	31	30
2015	7	16	6	26	52	0.223	-0.095	0.886	0.033	0.03	0	47.3	45.6	71	140	135	0	30	29
2015	7	16	6	36	52	0.144	0.075	0.886	0.039	0.036	0	43.4	42.1	74.4	131	128	0	30	30
2015	7	16	6	46	52	0.177	0.01	0.886	0.046	0.043	0	46	45.2	71.8	138	134	0	31	29
2015	7	16	6	56	52	0.151	0.036	0.886	0.039	0.039	0	46.4	45.2	71.4	138	135	0	30	30
2015	7	16	7	6	52	0.256	0.052	0.886	0.039	0.039	0	44.7	43.9	73.1	135	132	0	31	30
2015	7	16	7	16	52	0.217	0.016	0.886	0.043	0.039	0	43.9	43.9	74	133	132	0	31	30
2015	7	16	7	26	52	0.164	-0.036	0.886	0.039	0.039	0	48.6	47.3	70.1	143	140	0	30	30
2015	7	16	7	36	52	0.164	-0.007	0.886	0.043	0.039	0	44.3	44.3	74	134	133	0	31	30
2015	7	16	7	46	52	0.135	0.023	0.886	0.039	0.036	0	44.7	45.2	74	135	134	0	31	29
2015	7	16	7	56	52	0.138	0	0.886	0.036	0.033	0	47.3	46.4	73.1	140	138	0	30	30
2015	7	16	8	6	52	0.223	-0.013	0.886	0.033	0.03	0	47.3	46.9	72.7	140	139	0	30	30
2015	7	16	8	16	52	0.164	-0.016	0.889	0.039	0.036	0	49	48.2	72.7	145	141	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	16	8	26	52	0.253	0.03	0.889	0.039	0.039	0	46.9	46.9	71.8	140	139	0	31	30
2015	7	16	8	36	52	0.098	-0.049	0.889	0.033	0.03	0	48.2	47.7	73.5	142	141	0	30	30
2015	7	16	8	46	52	0.105	0.036	0.889	0.039	0.039	0	49	47.7	72.7	144	141	0	30	30
2015	7	16	8	56	52	0.141	0	0.889	0.039	0.036	0	51.6	49.9	69.2	150	146	0	30	30
2015	7	16	9	6	52	0.157	0	0.886	0.039	0.036	0	52	50.3	68.8	151	148	0	30	31
2015	7	16	9	16	52	0.154	0.033	0.886	0.039	0.036	0	52	51.2	68.4	152	148	0	31	29
2015	7	16	9	26	52	0.203	0.033	0.889	0.039	0.036	0	51.2	50.7	70.1	149	147	0	30	29
2015	7	16	9	36	52	0.276	0.056	0.889	0.036	0.033	0	51.6	51.2	70.1	150	148	0	30	29
2015	7	16	9	46	52	0.2	0.062	0.889	0.036	0.033	0	50.3	49	71.4	147	144	0	30	30
2015	7	16	9	56	52	0.141	0	0.889	0.033	0.03	0	52.5	51.6	69.2	153	150	0	31	30
2015	7	16	10	6	52	0.194	-0.026	0.886	0.033	0.03	0	51.2	51.2	69.7	149	149	0	30	30
2015	7	16	10	16	52	0.18	0.013	0.889	0.033	0.03	0	52.5	51.2	69.7	152	149	0	30	30
2015	7	16	10	26	52	0.157	0.016	0.886	0.036	0.033	0	52	52.5	70.5	152	151	0	31	29
2015	7	16	10	36	52	0.223	-0.003	0.886	0.033	0.03	0	53.3	53.3	69.2	154	153	0	30	29
2015	7	16	10	46	52	0.167	0.062	0.886	0.033	0.03	0	53.3	53.8	67.9	155	154	0	31	29
2015	7	16	10	56	52	0.213	0.056	0.886	0.033	0.03	0	54.2	53.8	66.2	157	154	0	31	29
2015	7	16	11	6	52	0.22	0.007	0.886	0.033	0.03	0	53.8	54.2	67.5	155	156	0	30	30
2015	7	16	11	16	52	0.151	0.036	0.886	0.033	0.03	0	54.6	54.6	66.7	157	156	0	30	29
2015	7	16	11	26	52	0.184	0.112	0.886	0.039	0.036	0	55.5	55.5	67.1	159	158	0	30	29
2015	7	16	11	36	52	0.177	0.02	0.886	0.033	0.03	0	55.9	55.9	66.2	160	160	0	30	30
2015	7	16	11	46	52	0.197	0.062	0.886	0.036	0.033	0	56.8	56.3	65.4	162	160	0	30	29
2015	7	16	11	56	52	0.243	0.059	0.886	0.036	0.033	0	56.3	56.3	64.1	162	160	0	31	29
2015	7	16	12	6	52	0.2	0.098	0.886	0.043	0.043	0	56.8	56.8	64.1	163	161	0	31	29
2015	7	16	12	16	52	0.121	0.066	0.883	0.033	0.03	0	58	56.8	63.6	165	162	0	30	30
2015	7	16	12	26	52	0.226	0.036	0.883	0.033	0.033	0	57.2	56.8	64.5	164	162	0	31	30
2015	7	16	12	36	52	0.21	0.098	0.883	0.039	0.036	0	57.6	57.2	64.1	165	163	0	31	30
2015	7	16	12	46	52	0.164	0.056	0.883	0.036	0.033	0	58.5	57.6	61.9	166	163	0	30	29
2015	7	16	12	56	52	0.154	0.043	0.883	0.033	0.03	0	58.9	57.6	61.9	167	163	0	30	29
2015	7	16	13	6	52	0.217	0.052	0.883	0.033	0.03	0	58.5	57.2	61.1	166	163	0	30	30
2015	7	16	13	16	52	0.223	0.131	0.883	0.036	0.033	0	58.9	58.5	62.8	167	165	0	30	29
2015	7	16	13	26	52	0.223	0.085	0.879	0.036	0.033	0	58.5	58.5	62.8	167	165	0	31	29
2015	7	16	13	36	52	0.236	0.052	0.879	0.036	0.033	0	59.3	58	63.6	169	165	0	31	30
2015	7	16	13	46	52	0.217	0.033	0.879	0.036	0.033	0	59.3	58.5	62.8	168	165	0	30	29
2015	7	16	13	56	52	0.207	0.082	0.879	0.039	0.039	0	60.2	58.5	61.1	170	165	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	16	14	6	52	0.213	0.075	0.879	0.039	0.036	0	59.8	58.9	59.8	169	166	0	30	29
2015	7	16	14	16	52	0.194	0.121	0.879	0.033	0.03	0	59.8	58.9	60.6	168	166	0	29	29
2015	7	16	14	26	52	0.23	0.164	0.876	0.039	0.036	0	59.8	58.5	60.6	169	166	0	30	30
2015	7	16	14	36	52	0.24	0.098	0.876	0.036	0.033	0	60.2	58.5	61.9	169	165	0	29	29
2015	7	16	14	46	52	0.226	0.095	0.876	0.033	0.03	0	60.2	59.3	60.6	170	167	0	30	29
2015	7	16	14	56	52	0.236	0.069	0.873	0.039	0.039	0	60.2	58.9	60.6	170	166	0	30	29
2015	7	16	15	6	52	0.141	0.108	0.873	0.039	0.036	0	60.2	58.9	61.1	170	166	0	30	29
2015	7	16	15	16	52	0.207	0.115	0.876	0.043	0.043	0	59.8	59.3	61.5	168	167	0	29	29
2015	7	16	15	26	52	0.259	0.056	0.876	0.033	0.03	0	58.5	58	60.6	166	164	0	30	29
2015	7	16	15	36	52	0.22	0.052	0.873	0.036	0.033	0	60.6	59.3	61.1	170	167	0	29	29
2015	7	16	15	46	52	0.151	0.059	0.876	0.033	0.03	0	59.8	59.3	58	169	167	0	30	29
2015	7	16	15	56	52	0.21	0.135	0.873	0.033	0.03	0	59.8	58.9	61.5	169	166	0	30	29
2015	7	16	16	6	52	0.197	0.19	0.873	0.033	0.03	0	59.3	57.6	61.5	167	164	0	29	30
2015	7	16	16	16	52	0.18	0.108	0.873	0.033	0.03	0	56.8	55.9	63.2	162	159	0	30	29
2015	7	16	16	26	52	0.217	0.02	0.873	0.036	0.033	0	58.5	57.6	63.6	166	163	0	30	29
2015	7	16	16	36	52	0.138	0.072	0.873	0.033	0.03	0	58	57.6	63.2	165	163	0	30	29
2015	7	16	16	46	52	0.177	-0.026	0.873	0.033	0.03	0	58	56.8	61.9	165	161	0	30	29
2015	7	16	16	56	52	0.157	0.131	0.873	0.036	0.033	0	57.2	57.2	62.8	163	161	0	30	28
2015	7	16	17	6	52	0.174	0.016	0.873	0.033	0.03	0	57.2	56.8	64.5	163	161	0	30	29
2015	7	16	17	16	52	0.138	0.036	0.873	0.039	0.036	0	53.3	53.3	65.8	154	153	0	30	29
2015	7	16	17	26	52	0.184	0.089	0.873	0.036	0.033	0	55.5	54.6	66.2	159	156	0	30	29
2015	7	16	17	36	52	0.177	0.033	0.873	0.036	0.033	0	51.2	50.7	67.5	149	147	0	30	29
2015	7	16	17	46	52	0.157	0.069	0.873	0.036	0.033	0	49	48.6	69.2	144	142	0	30	29
2015	7	16	17	56	52	0.18	0.03	0.873	0.036	0.033	0	48.6	46.9	69.7	143	138	0	30	29
2015	7	16	18	6	52	0.118	0.007	0.873	0.039	0.036	0	46.4	45.2	70.1	138	134	0	30	29
2015	7	16	18	16	52	0.233	0.056	0.873	0.036	0.033	0	47.3	45.2	69.7	140	134	0	30	29
2015	7	16	18	26	52	0.23	0.02	0.873	0.039	0.036	0	46	44.7	71	137	133	0	30	29
2015	7	16	18	36	52	0.154	-0.03	0.873	0.039	0.036	0	51.2	48.6	66.2	149	143	0	30	30
2015	7	16	18	46	52	0.154	0.01	0.869	0.036	0.033	0	53.8	51.2	64.5	154	148	0	29	29
2015	7	16	18	56	52	0.253	0.023	0.873	0.043	0.039	0	54.2	51.6	64.1	155	149	0	29	29
2015	7	16	19	6	52	0.23	0.046	0.873	0.039	0.039	0	54.2	52	63.6	156	150	0	30	29
2015	7	16	19	16	52	0.164	-0.036	0.873	0.046	0.043	0	58.5	55.9	58.5	166	159	0	30	29
2015	7	16	19	26	52	0.157	-0.023	0.873	0.039	0.039	0	55.5	53.3	61.9	158	153	0	29	29
2015	7	16	19	36	52	0.121	-0.056	0.873	0.039	0.039	0	52.5	50.3	64.9	152	146	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	16	19	46	52	0.177	-0.049	0.873	0.039	0.036	0	53.8	51.6	63.2	155	149	0	30	29
2015	7	16	19	56	52	0.171	0	0.873	0.033	0.03	0	53.8	51.2	63.6	155	148	0	30	29
2015	7	16	20	6	52	0.194	-0.056	0.873	0.033	0.03	0	50.7	49	65.8	148	143	0	30	29
2015	7	16	20	16	52	0.171	-0.039	0.873	0.043	0.039	0	52.5	50.3	64.9	152	146	0	30	29
2015	7	16	20	26	52	0.203	-0.046	0.873	0.039	0.036	0	52	49	65.8	150	143	0	29	29
2015	7	16	20	36	52	0.18	0.007	0.873	0.049	0.046	0	51.6	49.9	65.8	150	145	0	30	29
2015	7	16	20	46	52	0.256	-0.01	0.876	0.039	0.036	0	51.6	49.5	66.2	150	144	0	30	29
2015	7	16	20	56	52	0.174	-0.062	0.876	0.043	0.039	0	51.6	49.5	65.4	150	144	0	30	29
2015	7	16	21	6	52	0.18	-0.069	0.873	0.039	0.036	0	54.6	52.9	61.5	157	151	0	30	28
2015	7	16	21	16	52	0.121	0	0.873	0.039	0.036	0	51.2	49.5	65.4	149	144	0	30	29
2015	7	16	21	26	52	0.256	0.003	0.873	0.043	0.043	0	53.3	51.2	63.6	154	149	0	30	30
2015	7	16	21	36	52	0.259	0.016	0.873	0.043	0.039	0	50.7	48.6	66.2	148	142	0	30	29
2015	7	16	21	46	52	0.174	0	0.876	0.039	0.036	0	50.7	48.6	66.2	148	142	0	30	29
2015	7	16	21	56	52	0.24	-0.049	0.876	0.043	0.039	0	48.6	46.4	68.4	143	137	0	30	29
2015	7	16	22	6	52	0.174	-0.023	0.876	0.033	0.03	0	49.9	47.7	67.1	146	140	0	30	29
2015	7	16	22	16	52	0.243	0.056	0.876	0.039	0.036	0	48.2	46.4	68.8	142	137	0	30	29
2015	7	16	22	26	52	0.144	-0.056	0.876	0.039	0.036	0	49.9	47.7	67.5	147	140	0	31	29
2015	7	16	22	36	52	0.131	0.036	0.876	0.039	0.039	0	47.7	46.4	68.8	142	137	0	31	29
2015	7	16	22	46	52	0.22	-0.02	0.879	0.036	0.033	0	46.9	45.6	69.2	139	136	0	30	30
2015	7	16	22	56	52	0.213	-0.02	0.879	0.033	0.03	0	46.4	46	69.2	139	136	0	31	29
2015	7	16	23	6	52	0.207	0	0.879	0.039	0.036	0	47.7	46	69.2	141	136	0	30	29
2015	7	16	23	16	52	0.171	-0.013	0.879	0.039	0.036	0	48.6	46.9	68.4	144	138	0	31	29
2015	7	16	23	26	52	0.18	-0.036	0.879	0.039	0.039	0	46	44.3	70.5	137	132	0	30	29
2015	7	16	23	36	52	0.148	-0.013	0.879	0.039	0.036	0	45.2	43.9	70.5	135	132	0	30	30
2015	7	16	23	46	52	0.151	-0.039	0.879	0.043	0.039	0	45.2	43.9	71	136	132	0	31	30
2015	7	16	23	56	52	0.125	0.056	0.879	0.039	0.036	0	44.7	43.4	71.4	134	130	0	30	29
2015	7	17	0	6	52	0.22	-0.02	0.879	0.039	0.039	0	45.6	43.9	70.5	136	131	0	30	29
2015	7	17	0	16	52	0.23	-0.013	0.879	0.039	0.036	0	45.6	43.9	70.5	136	131	0	30	29
2015	7	17	0	26	52	0.141	-0.046	0.879	0.039	0.036	0	44.7	43	71.4	134	130	0	30	30
2015	7	17	0	36	52	0.246	0.016	0.879	0.039	0.036	0	44.7	43	71.4	134	130	0	30	30
2015	7	17	0	46	52	0.194	-0.026	0.879	0.033	0.03	0	44.7	43	71	134	130	0	30	30
2015	7	17	0	56	52	0.24	-0.043	0.879	0.036	0.033	0	46.4	44.3	69.7	138	133	0	30	30
2015	7	17	1	6	52	0.203	-0.007	0.879	0.033	0.03	0	46.9	46	68.8	140	136	0	31	29
2015	7	17	1	16	52	0.187	-0.059	0.879	0.036	0.033	0	45.6	43.4	70.5	136	130	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	17	1	26	52	0.151	0.016	0.879	0.039	0.036	0	44.7	43.9	70.5	135	131	0	31	29
2015	7	17	1	36	52	0.22	0.01	0.879	0.033	0.03	0	43.9	42.6	71	133	129	0	31	30
2015	7	17	1	46	52	0.167	-0.059	0.879	0.036	0.033	0	45.2	42.6	71	135	129	0	30	30
2015	7	17	1	56	52	0.184	-0.102	0.879	0.039	0.036	0	44.3	43	71	134	130	0	31	30
2015	7	17	2	6	52	0.148	0.026	0.879	0.043	0.039	0	43.9	43	72.2	133	130	0	31	30
2015	7	17	2	16	52	0.217	-0.016	0.879	0.036	0.033	0	44.3	43	71.8	133	129	0	30	29
2015	7	17	2	26	52	0.135	-0.039	0.879	0.033	0.03	0	47.3	45.6	68.8	141	136	0	31	30
2015	7	17	2	36	52	0.19	-0.007	0.876	0.039	0.036	0	44.7	43.4	71	134	131	0	30	30
2015	7	17	2	46	52	0.18	-0.039	0.879	0.036	0.033	0	44.3	43	71.4	134	129	0	31	29
2015	7	17	2	56	52	0.22	-0.043	0.876	0.039	0.036	0	46.4	44.7	69.7	138	133	0	30	29
2015	7	17	3	6	52	0.223	-0.036	0.879	0.043	0.039	0	43	42.1	71.8	131	128	0	31	30
2015	7	17	3	16	52	0.213	-0.036	0.876	0.039	0.039	0	44.3	42.6	71.4	133	129	0	30	30
2015	7	17	3	26	52	0.148	-0.049	0.876	0.039	0.036	0	44.7	43	70.5	135	130	0	31	30
2015	7	17	3	36	52	0.207	0.007	0.879	0.036	0.033	0	44.7	42.6	71.8	134	129	0	30	30
2015	7	17	3	46	52	0.187	-0.049	0.876	0.039	0.036	0	46	44.3	70.1	137	133	0	30	30
2015	7	17	3	56	52	0.19	-0.036	0.876	0.039	0.039	0	46.9	45.2	69.2	140	134	0	31	29
2015	7	17	4	6	52	0.187	-0.056	0.876	0.036	0.033	0	44.7	43	71.4	134	130	0	30	30
2015	7	17	4	16	52	0.131	-0.066	0.876	0.039	0.036	0	44.7	42.6	72.2	134	129	0	30	30
2015	7	17	4	26	52	0.24	-0.02	0.876	0.039	0.036	0	44.7	44.3	71	135	132	0	31	29
2015	7	17	4	36	52	0.184	0.013	0.876	0.043	0.039	0	45.2	44.3	70.5	135	132	0	30	29
2015	7	17	4	46	52	0.157	-0.079	0.876	0.046	0.043	0	46	43.4	70.1	138	131	0	31	30
2015	7	17	4	56	52	0.174	-0.052	0.876	0.039	0.036	0	44.3	43	71	134	130	0	31	30
2015	7	17	5	6	52	0.089	-0.01	0.876	0.039	0.036	0	44.7	43.9	71	134	132	0	30	30
2015	7	17	5	16	52	0.197	0.013	0.876	0.039	0.036	0	44.7	43.4	71	134	131	0	30	30
2015	7	17	5	26	52	0.236	0	0.876	0.039	0.039	0	44.7	43.4	71	135	131	0	31	30
2015	7	17	5	36	52	0.131	-0.049	0.876	0.039	0.039	0	45.2	43.4	70.5	135	131	0	30	30
2015	7	17	5	46	52	0.184	-0.013	0.876	0.043	0.043	0	44.3	43.4	71	134	131	0	31	30
2015	7	17	5	56	52	0.217	-0.052	0.876	0.039	0.039	0	45.6	44.7	69.7	137	133	0	31	29
2015	7	17	6	6	52	0.151	-0.023	0.876	0.039	0.039	0	46	44.7	68.8	138	134	0	31	30
2015	7	17	6	16	52	0.259	-0.072	0.876	0.036	0.033	0	46.4	44.3	69.2	138	133	0	30	30
2015	7	17	6	26	52	0.112	-0.036	0.876	0.039	0.036	0	45.2	43	70.5	135	129	0	30	29
2015	7	17	6	36	52	0.2	-0.085	0.873	0.039	0.036	0	46.9	44.7	68.8	140	134	0	31	30
2015	7	17	6	46	52	0.21	0.049	0.876	0.036	0.033	0	44.3	42.6	70.5	134	129	0	31	30
2015	7	17	6	56	52	0.18	0.007	0.876	0.036	0.033	0	44.3	42.6	71.4	133	129	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	17	7	6	52	0.164	-0.052	0.876	0.039	0.036	0	44.3	43.4	71	134	131	0	31	30
2015	7	17	7	16	52	0.161	-0.01	0.876	0.043	0.039	0	43.4	42.6	72.7	131	128	0	30	29
2015	7	17	7	26	52	0.144	0.01	0.876	0.033	0.03	0	43	41.3	72.7	131	126	0	31	30
2015	7	17	7	36	52	0.141	-0.039	0.873	0.036	0.033	0	45.6	44.7	69.2	137	134	0	31	30
2015	7	17	7	46	52	0.184	0.023	0.873	0.036	0.033	0	47.3	45.2	68.8	141	135	0	31	30
2015	7	17	7	56	52	0.115	-0.033	0.873	0.039	0.036	0	47.7	46.4	69.7	142	138	0	31	30
2015	7	17	8	6	52	0.18	-0.043	0.873	0.036	0.033	0	47.3	46.4	70.1	141	138	0	31	30
2015	7	17	8	16	52	0.269	-0.007	0.873	0.036	0.033	0	49	47.7	69.7	145	141	0	31	30
2015	7	17	8	26	52	0.167	0	0.873	0.039	0.036	0	48.6	47.7	69.7	143	141	0	30	30
2015	7	17	8	36	52	0.105	-0.049	0.873	0.036	0.033	0	48.6	48.2	69.2	143	142	0	30	30
2015	7	17	8	46	52	0.23	0	0.873	0.033	0.03	0	48.6	47.7	69.2	144	142	0	31	31
2015	7	17	8	56	52	0.164	-0.02	0.873	0.043	0.039	0	48.6	49.5	70.5	143	145	0	30	30
2015	7	17	9	6	52	0.2	0	0.873	0.036	0.033	0	49	48.2	70.1	144	142	0	30	30
2015	7	17	9	16	52	0.184	-0.03	0.873	0.039	0.036	0	49.5	48.6	69.2	145	143	0	30	30
2015	7	17	9	26	52	0.203	0.003	0.869	0.039	0.036	0	50.7	49.5	68.4	148	145	0	30	30
2015	7	17	9	36	52	0.2	0.003	0.869	0.039	0.036	0	51.2	51.2	68.4	150	149	0	31	30
2015	7	17	9	46	52	0.157	0.039	0.869	0.036	0.033	0	52.9	51.6	66.7	154	150	0	31	30
2015	7	17	9	56	52	0.161	-0.033	0.869	0.039	0.036	0	51.2	51.6	67.9	150	150	0	31	30
2015	7	17	10	6	52	0.184	0.075	0.866	0.036	0.033	0	52	51.6	67.1	151	151	0	30	31
2015	7	17	10	16	52	0.148	0.013	0.866	0.036	0.033	0	52	53.8	68.4	151	154	0	30	29
2015	7	17	10	26	52	0.233	-0.016	0.866	0.036	0.033	0	53.3	54.2	66.7	154	156	0	30	30
2015	7	17	10	36	52	0.194	0.033	0.866	0.033	0.03	0	53.8	54.2	67.5	156	156	0	31	30
2015	7	17	10	46	52	0.128	0.066	0.866	0.033	0.03	0	53.3	54.6	67.1	155	157	0	31	30
2015	7	17	10	56	52	0.157	0.085	0.866	0.03	0.03	0	54.2	55	66.2	156	158	0	30	30
2015	7	17	11	6	52	0.207	0.069	0.866	0.036	0.033	0	53.8	55	66.7	155	158	0	30	30
2015	7	17	11	16	52	0.154	0	0.866	0.033	0.03	0	55.5	56.3	64.9	159	160	0	30	29
2015	7	17	11	26	52	0.171	0.056	0.866	0.036	0.033	0	55.9	56.3	64.5	160	161	0	30	30
2015	7	17	11	36	52	0.174	0.102	0.863	0.033	0.03	0	55.9	57.2	61.9	161	163	0	31	30
2015	7	17	11	46	52	0.164	0.072	0.863	0.033	0.033	0	56.8	58	63.6	162	164	0	30	29
2015	7	17	11	56	52	0.22	0.062	0.863	0.033	0.03	0	57.6	57.2	63.2	165	163	0	31	30
2015	7	17	12	6	52	0.203	0.082	0.863	0.033	0.03	0	57.6	57.6	64.5	165	164	0	31	30
2015	7	17	12	16	52	0.213	0.069	0.863	0.033	0.03	0	57.2	58	63.2	164	165	0	31	30
2015	7	17	12	26	52	0.249	0.108	0.863	0.033	0.03	0	58.5	58.5	63.2	167	166	0	31	30
2015	7	17	12	36	52	0.19	0.102	0.863	0.036	0.033	0	58.9	58.9	62.8	167	166	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	17	12	46	52	0.174	0.069	0.86	0.033	0.03	0	58.5	58.9	65.4	167	166	0	31	29
2015	7	17	12	56	52	0.108	0.072	0.86	0.033	0.03	0	59.3	59.8	61.1	168	168	0	30	29
2015	7	17	13	6	52	0.138	0.072	0.86	0.039	0.036	0	59.3	58.9	61.9	168	167	0	30	30
2015	7	17	13	16	52	0.128	0.007	0.863	0.036	0.033	0	59.8	59.3	62.8	169	167	0	30	29
2015	7	17	13	26	52	0.19	0.046	0.863	0.033	0.03	0	59.3	58.9	61.9	169	166	0	31	29
2015	7	17	13	36	52	0.233	0.082	0.863	0.033	0.03	0	59.3	58.9	61.9	168	167	0	30	30
2015	7	17	13	46	52	0.161	0.138	0.863	0.036	0.033	0	59.8	59.8	63.2	169	168	0	30	29
2015	7	17	13	56	52	0.062	0.007	0.863	0.03	0.03	0	60.2	59.3	62.8	170	168	0	30	30
2015	7	17	14	6	52	0.171	0.121	0.863	0.036	0.033	0	60.6	59.8	61.1	171	168	0	30	29
2015	7	17	14	16	52	0.194	0.128	0.863	0.036	0.033	0	60.2	60.2	61.9	170	169	0	30	29
2015	7	17	14	26	52	0.171	0.056	0.863	0.039	0.036	0	59.8	59.8	61.1	169	169	0	30	30
2015	7	17	14	36	52	0.217	0.056	0.86	0.033	0.03	0	60.6	59.3	62.4	170	167	0	29	29
2015	7	17	14	46	52	0.154	0.095	0.863	0.036	0.033	0	60.6	59.8	60.6	171	168	0	30	29
2015	7	17	14	56	52	0.194	0.092	0.86	0.039	0.036	0	59.8	59.3	61.5	169	168	0	30	30
2015	7	17	15	6	52	0.174	0.062	0.86	0.039	0.036	0	59.8	59.8	62.4	169	168	0	30	29
2015	7	17	15	16	52	0.174	0.131	0.863	0.033	0.03	0	60.2	59.8	61.5	169	169	0	29	30
2015	7	17	15	26	52	0.157	0.056	0.86	0.039	0.036	0	59.8	60.2	59.8	169	169	0	30	29
2015	7	17	15	36	52	0.194	0.033	0.86	0.033	0.03	0	55	55.5	65.4	158	158	0	30	29
2015	7	17	15	46	52	0.23	0.052	0.86	0.036	0.033	0	60.6	60.2	59.8	171	169	0	30	29
2015	7	17	15	56	52	0.157	0.062	0.86	0.033	0.03	0	59.8	59.8	62.4	169	168	0	30	29
2015	7	17	16	6	52	0.21	0.125	0.86	0.036	0.033	0	59.3	59.3	61.9	168	167	0	30	29
2015	7	17	16	16	52	0.131	0.102	0.86	0.033	0.03	0	60.2	59.3	61.9	169	167	0	29	29
2015	7	17	16	26	52	0.21	0.069	0.86	0.033	0.03	0	59.3	58.9	62.4	168	166	0	30	29
2015	7	17	16	36	52	0.138	0.072	0.86	0.033	0.03	0	58.5	58.9	63.2	166	166	0	30	29
2015	7	17	16	46	52	0.125	0.079	0.86	0.039	0.036	0	58	58.5	63.2	165	165	0	30	29
2015	7	17	16	56	52	0.161	0.082	0.86	0.033	0.03	0	58.5	57.6	64.5	166	163	0	30	29
2015	7	17	17	6	52	0.217	0	0.86	0.036	0.033	0	57.6	57.6	66.7	164	163	0	30	29
2015	7	17	17	16	52	0.243	0.125	0.86	0.036	0.033	0	57.6	57.2	64.5	163	162	0	29	29
2015	7	17	17	26	52	0.259	0.039	0.86	0.039	0.036	0	57.6	56.8	66.7	164	161	0	30	29
2015	7	17	17	36	52	0.19	0.115	0.86	0.033	0.03	0	53.8	54.6	68.8	155	156	0	30	29
2015	7	17	17	46	52	0.154	0.056	0.86	0.036	0.033	0	51.6	53.3	71	149	152	0	29	28
2015	7	17	17	56	52	0.167	-0.02	0.856	0.036	0.033	0	49.9	50.7	71	146	147	0	30	29
2015	7	17	18	6	52	0.194	-0.007	0.856	0.033	0.03	0	47.7	49	72.2	141	143	0	30	29
2015	7	17	18	16	52	0.157	0.023	0.856	0.039	0.039	0	46.4	46.9	73.5	138	138	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	17	18	26	52	0.115	0.043	0.86	0.036	0.033	0	46.4	45.2	74	138	134	0	30	29
2015	7	17	18	36	52	0.197	-0.036	0.856	0.039	0.036	0	46.4	44.3	74	137	132	0	29	29
2015	7	17	18	46	52	0.164	-0.023	0.856	0.043	0.039	0	47.7	45.2	72.7	141	134	0	30	29
2015	7	17	18	56	52	0.148	-0.03	0.856	0.036	0.033	0	47.3	45.2	72.7	140	134	0	30	29
2015	7	17	19	6	52	0.144	0.059	0.856	0.039	0.036	0	46.4	45.2	72.2	138	134	0	30	29
2015	7	17	19	16	52	0.131	0	0.856	0.039	0.039	0	47.3	45.2	71.8	140	134	0	30	29
2015	7	17	19	26	52	0.141	0.023	0.856	0.036	0.033	0	49.9	47.3	71	146	139	0	30	29
2015	7	17	19	36	52	0.115	-0.039	0.856	0.039	0.039	0	47.7	45.6	72.2	141	135	0	30	29
2015	7	17	19	46	52	0.112	-0.039	0.856	0.049	0.046	0	47.7	45.6	72.2	141	135	0	30	29
2015	7	17	19	56	52	0.187	0.013	0.856	0.039	0.036	0	46.4	44.7	73.5	138	133	0	30	29
2015	7	17	20	6	52	0.167	-0.033	0.856	0.039	0.036	0	46.4	44.7	73.5	138	133	0	30	29
2015	7	17	20	16	52	0.089	-0.01	0.856	0.039	0.036	0	47.3	45.2	72.7	140	133	0	30	28
2015	7	17	20	26	52	0.154	-0.016	0.856	0.043	0.043	0	46	44.3	73.5	137	132	0	30	29
2015	7	17	20	36	52	0.157	-0.03	0.856	0.036	0.033	0	46	44.3	74	137	132	0	30	29
2015	7	17	20	46	52	0.184	-0.049	0.856	0.039	0.036	0	45.6	44.3	74	136	132	0	30	29
2015	7	17	20	56	52	0.19	0.02	0.856	0.033	0.03	0	46.4	44.7	72.7	138	133	0	30	29
2015	7	17	21	6	52	0.19	-0.059	0.856	0.033	0.03	0	46.4	45.2	73.1	138	134	0	30	29
2015	7	17	21	16	52	0.154	-0.056	0.856	0.039	0.036	0	46	44.7	73.5	137	133	0	30	29
2015	7	17	21	26	52	0.177	-0.033	0.856	0.039	0.036	0	44.7	43.4	73.5	135	130	0	31	29
2015	7	17	21	36	52	0.075	-0.066	0.856	0.036	0.033	0	45.6	43.9	74	136	131	0	30	29
2015	7	17	21	46	52	0.151	0.072	0.853	0.036	0.033	0	45.2	44.3	73.5	135	131	0	30	28
2015	7	17	21	56	52	0.095	0.03	0.853	0.036	0.033	0	45.2	43.9	74	135	131	0	30	29
2015	7	17	22	6	52	0.164	0.039	0.853	0.039	0.036	0	44.3	43.4	74.8	133	130	0	30	29
2015	7	17	22	16	52	0.135	-0.059	0.853	0.039	0.036	0	46	44.3	73.5	137	132	0	30	29
2015	7	17	22	26	52	0.157	0.023	0.853	0.033	0.03	0	44.7	44.3	74	134	131	0	30	28
2015	7	17	22	36	52	0.157	-0.007	0.853	0.036	0.033	0	49.5	47.3	68.4	144	139	0	29	29
2015	7	17	22	46	52	0.131	-0.036	0.853	0.033	0.03	0	46	45.2	73.5	137	134	0	30	29
2015	7	17	22	56	52	0.157	-0.007	0.853	0.033	0.03	0	46.9	44.7	72.7	139	134	0	30	30
2015	7	17	23	6	52	0.148	0.03	0.853	0.036	0.033	0	45.6	44.3	73.1	137	132	0	31	29
2015	7	17	23	16	52	0.167	-0.02	0.853	0.033	0.03	0	46	43	74	137	131	0	30	31
2015	7	17	23	26	52	0.187	-0.03	0.853	0.033	0.03	0	45.2	43.9	74.4	135	131	0	30	29
2015	7	17	23	36	52	0.18	0.007	0.853	0.043	0.039	0	43.4	42.6	74.8	132	128	0	31	29
2015	7	17	23	46	52	0.131	-0.043	0.853	0.049	0.049	0	45.2	43.4	73.1	135	130	0	30	29
2015	7	17	23	56	52	0.125	-0.02	0.853	0.036	0.033	0	43.9	43	74.4	133	129	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	18	0	6	52	0.135	0.03	0.853	0.039	0.036	0	43.9	43.4	74.4	132	130	0	30	29
2015	7	18	0	16	52	0.072	-0.039	0.853	0.039	0.036	0	45.2	44.3	74	135	132	0	30	29
2015	7	18	0	26	52	0.151	-0.052	0.853	0.039	0.039	0	45.6	44.3	74	136	132	0	30	29
2015	7	18	0	36	52	0.18	-0.013	0.85	0.036	0.033	0	44.7	44.3	73.1	134	132	0	30	29
2015	7	18	0	46	52	0.121	-0.01	0.85	0.036	0.033	0	46	43.9	73.5	137	132	0	30	30
2015	7	18	0	56	52	0.154	-0.01	0.85	0.036	0.033	0	45.6	43.9	72.7	137	132	0	31	30
2015	7	18	1	6	52	0.112	0.013	0.85	0.039	0.036	0	47.7	45.2	71.8	141	135	0	30	30
2015	7	18	1	16	52	0.161	-0.016	0.85	0.033	0.03	0	46	43.9	73.1	137	132	0	30	30
2015	7	18	1	26	52	0.174	0	0.85	0.033	0.03	0	46	44.3	72.7	138	133	0	31	30
2015	7	18	1	36	52	0.125	-0.023	0.85	0.033	0.03	0	45.2	43.4	73.5	135	130	0	30	29
2015	7	18	1	46	52	0.131	-0.016	0.85	0.033	0.03	0	43.9	42.6	74	132	129	0	30	30
2015	7	18	1	56	52	0.144	0.056	0.85	0.039	0.036	0	43.9	42.1	74.4	132	128	0	30	30
2015	7	18	2	6	52	0.148	-0.056	0.85	0.043	0.039	0	44.7	43.9	72.7	134	131	0	30	29
2015	7	18	2	16	52	0.184	-0.075	0.85	0.039	0.036	0	44.3	43.4	74.4	134	130	0	31	29
2015	7	18	2	26	52	0.02	-0.003	0.85	0.043	0.039	0	43.4	41.7	74.4	131	127	0	30	30
2015	7	18	2	36	52	0.079	0.007	0.85	0.033	0.03	0	44.3	42.1	74	134	128	0	31	30
2015	7	18	2	46	52	0.187	-0.01	0.85	0.039	0.036	0	43.4	43	74	132	129	0	31	29
2015	7	18	2	56	52	0.164	0.043	0.846	0.043	0.039	0	44.3	42.6	73.1	133	129	0	30	30
2015	7	18	3	6	52	0.128	-0.069	0.846	0.039	0.036	0	43.9	43	73.5	133	130	0	31	30
2015	7	18	3	16	52	0.164	-0.02	0.846	0.033	0.03	0	44.3	43	73.1	133	130	0	30	30
2015	7	18	3	26	52	0.098	-0.072	0.846	0.036	0.033	0	43.4	43.4	74.4	131	130	0	30	29
2015	7	18	3	36	52	0.135	-0.056	0.846	0.036	0.033	0	44.3	42.1	74	133	128	0	30	30
2015	7	18	3	46	52	0.167	-0.085	0.846	0.033	0.03	0	42.6	42.6	73.5	130	128	0	31	29
2015	7	18	3	56	52	0.151	-0.075	0.846	0.033	0.03	0	42.6	42.6	74	130	129	0	31	30
2015	7	18	4	6	52	0.151	-0.062	0.846	0.033	0.03	0	43.9	43.4	73.1	132	130	0	30	29
2015	7	18	4	16	52	0.187	-0.02	0.846	0.033	0.03	0	43.4	42.1	73.5	131	128	0	30	30
2015	7	18	4	26	52	0.131	-0.003	0.846	0.036	0.033	0	45.2	44.3	71.4	136	132	0	31	29
2015	7	18	4	36	52	0.135	0.046	0.846	0.039	0.036	0	46.9	44.7	70.5	139	134	0	30	30
2015	7	18	4	46	52	0.161	0.016	0.846	0.033	0.03	0	44.7	44.3	72.2	135	133	0	31	30
2015	7	18	4	56	52	0.174	0.033	0.846	0.036	0.033	0	44.3	43.9	73.1	134	132	0	31	30
2015	7	18	5	6	52	0.187	-0.049	0.846	0.036	0.033	0	44.7	43.9	72.7	135	132	0	31	30
2015	7	18	5	16	52	0.161	0.036	0.846	0.039	0.036	0	43.9	42.6	74	133	129	0	31	30
2015	7	18	5	26	52	0.184	-0.02	0.846	0.036	0.033	0	44.3	43.9	74	133	132	0	30	30
2015	7	18	5	36	52	0.079	0.023	0.85	0.039	0.036	0	44.3	42.6	74	134	129	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	18	5	46	52	0.115	-0.01	0.85	0.036	0.033	0	45.6	43.4	73.5	136	131	0	30	30
2015	7	18	5	56	52	0.131	0.02	0.85	0.036	0.033	0	44.3	43.9	73.5	134	131	0	31	29
2015	7	18	6	6	52	0.066	0.039	0.85	0.036	0.033	0	44.3	43	74	134	130	0	31	30
2015	7	18	6	16	52	0.144	-0.062	0.85	0.039	0.036	0	43.9	42.6	75.3	132	129	0	30	30
2015	7	18	6	26	52	0.072	-0.052	0.85	0.039	0.036	0	45.2	44.3	73.5	136	132	0	31	29
2015	7	18	6	36	52	0.171	-0.026	0.85	0.036	0.033	0	43	41.3	75.7	130	126	0	30	30
2015	7	18	6	46	52	0.19	0	0.853	0.033	0.03	0	42.1	41.7	76.5	129	127	0	31	30
2015	7	18	6	56	52	0.157	-0.092	0.853	0.033	0.03	0	42.6	41.3	76.5	129	126	0	30	30
2015	7	18	7	6	52	0.125	-0.039	0.853	0.036	0.033	0	43	41.7	76.1	131	127	0	31	30
2015	7	18	7	16	52	0.18	-0.046	0.853	0.033	0.03	0	41.7	40.9	77	127	125	0	30	30
2015	7	18	7	26	52	0.157	0.007	0.853	0.043	0.039	0	42.6	41.3	76.5	130	126	0	31	30
2015	7	18	7	36	52	0.082	-0.016	0.853	0.036	0.033	0	43	42.1	77	131	128	0	31	30
2015	7	18	7	46	52	0.112	-0.007	0.853	0.039	0.039	0	42.6	41.7	75.7	130	127	0	31	30
2015	7	18	7	56	52	0.089	-0.049	0.856	0.033	0.03	0	44.3	43.4	75.3	134	130	0	31	29
2015	7	18	8	6	52	0.125	-0.082	0.856	0.036	0.033	0	48.2	46.9	74.8	142	138	0	30	29
2015	7	18	8	16	52	0.161	0.052	0.856	0.039	0.036	0	48.2	49.5	74	143	145	0	31	30
2015	7	18	8	26	52	0.23	-0.007	0.856	0.043	0.039	0	48.6	48.6	74	144	143	0	31	30
2015	7	18	8	36	52	0.171	0	0.856	0.033	0.03	0	49	48.6	72.2	144	143	0	30	30
2015	7	18	8	46	52	0.112	0	0.856	0.039	0.036	0	48.6	49	73.1	144	143	0	31	29
2015	7	18	8	56	52	0.144	0.072	0.856	0.036	0.033	0	49.9	49.5	73.1	146	145	0	30	30
2015	7	18	9	6	52	0.154	0.036	0.856	0.033	0.03	0	49	49.5	72.7	145	145	0	31	30
2015	7	18	9	16	52	0.125	0.059	0.86	0.033	0.03	0	50.3	50.7	71	148	148	0	31	30
2015	7	18	9	26	52	0.105	0.016	0.86	0.033	0.03	0	52	51.6	71.4	151	149	0	30	29
2015	7	18	9	36	52	0.184	0.023	0.86	0.033	0.03	0	52.5	52	70.5	153	151	0	31	30
2015	7	18	9	46	52	0.135	0.095	0.86	0.036	0.033	0	53.8	52.9	68.8	155	153	0	30	30
2015	7	18	9	56	52	0.135	0.056	0.86	0.033	0.03	0	54.2	52.5	68.8	156	152	0	30	30
2015	7	18	10	6	52	0.164	0.02	0.86	0.033	0.03	0	53.3	53.3	68.8	155	154	0	31	30
2015	7	18	10	16	52	0.108	0.056	0.86	0.036	0.033	0	53.3	53.8	68.8	155	155	0	31	30
2015	7	18	10	26	52	0.203	0.033	0.86	0.033	0.03	0	54.2	54.2	68.4	156	155	0	30	29
2015	7	18	10	36	52	0.164	0.036	0.86	0.033	0.03	0	54.6	54.6	66.7	157	156	0	30	29
2015	7	18	10	46	52	0.171	0.075	0.86	0.039	0.036	0	53.8	54.6	66.7	156	157	0	31	30
2015	7	18	10	56	52	0.164	0.069	0.86	0.036	0.033	0	54.2	54.2	68.4	157	156	0	31	30
2015	7	18	11	6	52	0.157	0.046	0.86	0.036	0.033	0	55.5	55.5	66.7	160	159	0	31	30
2015	7	18	11	16	52	0.164	0.079	0.86	0.036	0.033	0	55	55.5	66.7	158	159	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	18	11	26	52	0.141	0.072	0.86	0.033	0.03	0	55.5	56.8	64.5	159	161	0	30	29
2015	7	18	11	36	52	0.157	0.085	0.86	0.036	0.033	0	55	56.3	65.4	159	161	0	31	30
2015	7	18	11	46	52	0.2	0.112	0.863	0.039	0.036	0	57.2	57.2	64.9	163	162	0	30	29
2015	7	18	11	56	52	0.128	0.056	0.86	0.033	0.03	0	56.8	57.2	63.2	163	163	0	31	30
2015	7	18	12	6	52	0.121	0.121	0.86	0.036	0.033	0	56.8	58	65.4	163	164	0	31	29
2015	7	18	12	16	52	0.197	0.056	0.86	0.033	0.03	0	57.6	57.2	63.2	164	163	0	30	30
2015	7	18	12	26	52	0.144	0.108	0.863	0.033	0.03	0	57.2	57.2	65.4	164	163	0	31	30
2015	7	18	12	36	52	0.203	0.098	0.863	0.03	0.03	0	57.2	57.2	65.4	163	163	0	30	30
2015	7	18	12	46	52	0.194	0.092	0.863	0.033	0.03	0	59.3	58.9	63.2	168	167	0	30	30
2015	7	18	12	56	52	0.157	0.112	0.863	0.036	0.033	0	59.3	58.9	61.1	169	167	0	31	30
2015	7	18	13	6	52	0.262	0.125	0.863	0.033	0.03	0	59.3	59.3	61.9	168	167	0	30	29
2015	7	18	13	16	52	0.2	0.075	0.863	0.033	0.03	0	56.3	57.2	64.1	161	162	0	30	29
2015	7	18	13	26	52	0.151	0.026	0.863	0.036	0.033	0	52.9	53.3	67.1	153	154	0	30	30
2015	7	18	13	36	52	0.121	0.115	0.866	0.039	0.039	0	56.8	57.2	64.1	162	162	0	30	29
2015	7	18	13	46	52	0.164	0.085	0.866	0.036	0.033	0	60.6	59.8	60.6	171	168	0	30	29
2015	7	18	13	56	52	0.217	0.052	0.866	0.039	0.039	0	59.3	58.9	61.9	169	167	0	31	30
2015	7	18	14	6	52	0.115	0.089	0.863	0.043	0.039	0	60.6	59.8	55.9	171	168	0	30	29
2015	7	18	14	16	52	0.2	0.089	0.863	0.039	0.036	0	59.3	58.5	57.2	168	165	0	30	29
2015	7	18	14	26	52	0.144	0.112	0.863	0.039	0.036	0	60.2	58.9	55.5	170	167	0	30	30
2015	7	18	14	36	52	0.138	0.144	0.863	0.039	0.039	0	59.3	59.3	58	169	167	0	31	29
2015	7	18	14	46	52	0.223	0.036	0.866	0.033	0.03	0	59.8	58	59.3	168	164	0	29	29
2015	7	18	14	56	52	0.18	0.108	0.863	0.033	0.03	0	58.5	58	58.9	166	164	0	30	29
2015	7	18	15	6	52	0.207	0.118	0.866	0.036	0.033	0	59.3	58.5	58.5	168	165	0	30	29
2015	7	18	15	16	52	0.141	0.092	0.863	0.036	0.033	0	61.1	60.2	55.5	172	169	0	30	29
2015	7	18	15	26	52	0.138	0.036	0.866	0.033	0.03	0	59.8	58.9	57.6	169	167	0	30	30
2015	7	18	15	36	52	0.151	0.039	0.866	0.039	0.036	0	58.5	57.6	60.6	166	163	0	30	29
2015	7	18	15	46	52	0.194	0.082	0.866	0.036	0.033	0	59.8	58.9	58.5	169	167	0	30	30
2015	7	18	15	56	52	0.207	0.102	0.866	0.033	0.03	0	59.8	59.3	58.9	168	167	0	29	29
2015	7	18	16	6	52	0.24	0.105	0.866	0.033	0.03	0	56.8	57.2	61.1	162	161	0	30	28
2015	7	18	16	16	52	0.167	0.036	0.866	0.033	0.03	0	58	58	58.9	166	164	0	31	29
2015	7	18	16	26	52	0.19	0.112	0.869	0.039	0.036	0	58	57.6	58.5	165	163	0	30	29
2015	7	18	16	36	52	0.174	0.03	0.869	0.036	0.033	0	50.7	50.3	65.4	148	146	0	30	29
2015	7	18	16	46	52	0.18	0.056	0.869	0.033	0.03	0	50.7	49.9	64.9	148	145	0	30	29
2015	7	18	16	56	52	0.131	0.069	0.869	0.033	0.03	0	50.7	49.9	65.4	148	145	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	18	17	6	52	0.243	0.013	0.869	0.039	0.036	0	52	51.2	61.9	152	148	0	31	29
2015	7	18	17	16	52	0.171	0.016	0.873	0.039	0.036	0	50.7	49.5	64.5	149	144	0	31	29
2015	7	18	17	26	52	0.226	0.089	0.873	0.036	0.033	0	51.2	49.9	64.5	149	145	0	30	29
2015	7	18	17	36	52	0.22	0.016	0.873	0.039	0.036	0	50.7	49	65.8	148	143	0	30	29
2015	7	18	17	46	52	0.112	-0.016	0.873	0.036	0.033	0	51.2	49.5	65.4	149	144	0	30	29
2015	7	18	17	56	52	0.171	-0.02	0.876	0.039	0.036	0	52.5	51.6	63.2	153	149	0	31	29
2015	7	18	18	6	52	0.249	-0.01	0.879	0.036	0.033	0	55.5	54.2	58.5	159	155	0	30	29
2015	7	18	18	16	52	0.184	0.082	0.879	0.039	0.036	0	56.3	54.6	58.9	161	156	0	30	29
2015	7	18	18	26	52	0.171	-0.098	0.883	0.039	0.039	0	56.3	54.2	60.6	161	155	0	30	29
2015	7	18	18	36	52	0.164	0.069	0.883	0.043	0.039	0	58.5	56.8	58	166	161	0	30	29
2015	7	18	18	46	52	0.187	-0.036	0.883	0.039	0.039	0	54.6	52.9	61.5	158	153	0	31	30
2015	7	18	18	56	52	0.108	-0.02	0.883	0.036	0.033	0	53.8	52	60.6	155	150	0	30	29
2015	7	18	19	6	52	0.174	-0.023	0.883	0.033	0.03	0	52	49.5	64.1	151	145	0	30	30
2015	7	18	19	16	52	0.102	-0.007	0.886	0.039	0.036	0	55.5	53.3	61.5	159	154	0	30	30
2015	7	18	19	26	52	0.236	-0.092	0.886	0.036	0.033	0	55.5	52.9	62.8	159	153	0	30	30
2015	7	18	19	36	52	0.128	-0.039	0.886	0.039	0.039	0	53.8	52	64.5	155	150	0	30	29
2015	7	18	19	46	52	0.18	-0.056	0.886	0.033	0.03	0	54.2	52.5	63.6	156	151	0	30	29
2015	7	18	19	56	52	0.167	-0.016	0.886	0.043	0.039	0	55.5	53.8	62.8	159	154	0	30	29
2015	7	18	20	6	52	0.2	-0.066	0.886	0.036	0.033	0	53.8	51.2	64.9	155	149	0	30	30
2015	7	18	20	16	52	0.148	0	0.886	0.039	0.039	0	55.9	54.2	62.4	160	155	0	30	29
2015	7	18	20	26	52	0.157	-0.013	0.886	0.039	0.039	0	53.8	51.6	63.2	155	150	0	30	30
2015	7	18	20	36	52	0.141	0.072	0.889	0.039	0.036	0	56.3	54.2	61.5	161	155	0	30	29
2015	7	18	20	46	52	0.164	0.016	0.889	0.043	0.039	0	54.2	52.5	64.1	156	151	0	30	29
2015	7	18	20	56	52	0.243	-0.082	0.889	0.043	0.039	0	55.9	53.8	60.6	160	155	0	30	30
2015	7	18	21	6	52	0.171	-0.033	0.889	0.043	0.039	0	52.9	51.2	65.4	153	148	0	30	29
2015	7	18	21	16	52	0.243	0.016	0.889	0.039	0.036	0	51.6	49.5	67.1	150	145	0	30	30
2015	7	18	21	26	52	0.217	-0.049	0.889	0.039	0.039	0	49.9	48.6	68.8	146	142	0	30	29
2015	7	18	21	36	52	0.151	-0.02	0.889	0.036	0.033	0	47.3	46.4	72.2	140	137	0	30	29
2015	7	18	21	46	52	0.161	0.036	0.889	0.036	0.033	0	47.3	44.3	72.7	140	133	0	30	30
2015	7	18	21	56	52	0.184	0.013	0.889	0.043	0.039	0	50.7	49.5	68.8	148	145	0	30	30
2015	7	18	22	6	52	0.184	-0.02	0.889	0.036	0.033	0	45.6	44.7	73.5	137	135	0	31	31
2015	7	18	22	16	52	0.157	-0.02	0.889	0.036	0.033	0	46.4	44.7	73.1	138	134	0	30	30
2015	7	18	22	26	52	0.19	-0.039	0.889	0.039	0.036	0	45.6	45.2	74.4	136	134	0	30	29
2015	7	18	22	36	52	0.217	-0.003	0.889	0.039	0.036	0	45.2	44.3	74	135	132	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	18	22	46	52	0.19	0.046	0.889	0.039	0.036	0	49	47.7	70.5	144	140	0	30	29
2015	7	18	22	56	52	0.21	0.026	0.889	0.039	0.036	0	45.2	44.3	74.4	136	133	0	31	30
2015	7	18	23	6	52	0.226	-0.043	0.889	0.033	0.03	0	46.4	45.2	73.5	138	135	0	30	30
2015	7	18	23	16	52	0.148	0.036	0.889	0.036	0.033	0	46.9	46	72.2	139	137	0	30	30
2015	7	18	23	26	52	0.262	-0.023	0.889	0.036	0.033	0	45.2	44.7	73.5	136	133	0	31	29
2015	7	18	23	36	52	0.197	-0.02	0.889	0.039	0.039	0	45.2	44.7	74.4	136	134	0	31	30
2015	7	18	23	46	52	0.184	-0.02	0.889	0.039	0.039	0	46.9	45.6	73.5	139	135	0	30	29
2015	7	18	23	56	52	0.2	0	0.889	0.033	0.03	0	44.7	44.3	74.8	135	133	0	31	30
2015	7	19	0	6	52	0.138	-0.026	0.889	0.036	0.033	0	44.3	42.1	75.3	133	128	0	30	30
2015	7	19	0	16	52	0.223	0.062	0.889	0.039	0.036	0	44.7	43	74.8	134	129	0	30	29
2015	7	19	0	26	52	0.207	-0.039	0.889	0.049	0.049	0	44.3	43.4	74.8	133	131	0	30	30
2015	7	19	0	36	52	0.217	-0.039	0.892	0.036	0.033	0	44.3	43.4	75.7	133	130	0	30	29
2015	7	19	0	46	52	0.21	-0.033	0.892	0.039	0.036	0	44.7	43	75.7	134	130	0	30	30
2015	7	19	0	56	52	0.236	-0.013	0.892	0.036	0.033	0	44.3	43.9	74.4	133	131	0	30	29
2015	7	19	1	6	52	0.118	0.023	0.892	0.039	0.036	0	44.3	43	75.7	134	130	0	31	30
2015	7	19	1	16	52	0.125	0.043	0.892	0.036	0.033	0	43	43	75.7	131	130	0	31	30
2015	7	19	1	26	52	0.131	0.02	0.889	0.039	0.036	0	45.2	43.9	74.8	136	132	0	31	30
2015	7	19	1	36	52	0.217	0	0.889	0.036	0.033	0	43.9	43	75.7	133	130	0	31	30
2015	7	19	1	46	52	0.203	-0.066	0.889	0.039	0.036	0	43.9	43	75.7	132	130	0	30	30
2015	7	19	1	56	52	0.2	0	0.892	0.036	0.033	0	44.7	43.4	74.8	135	131	0	31	30
2015	7	19	2	6	52	0.148	-0.092	0.892	0.043	0.039	0	43.9	43	76.1	133	130	0	31	30
2015	7	19	2	16	52	0.203	0	0.892	0.033	0.03	0	43.9	43.4	76.1	133	131	0	31	30
2015	7	19	2	26	52	0.266	0.043	0.892	0.039	0.036	0	44.3	42.6	76.5	133	129	0	30	30
2015	7	19	2	36	52	0.164	0.03	0.892	0.033	0.03	0	46.4	44.7	74.4	138	134	0	30	30
2015	7	19	2	46	52	0.233	0.026	0.889	0.039	0.039	0	46.9	45.2	74.4	139	135	0	30	30
2015	7	19	2	56	52	0.213	0.023	0.892	0.036	0.033	0	45.6	44.3	74.8	136	133	0	30	30
2015	7	19	3	6	52	0.259	0.066	0.892	0.046	0.043	0	45.6	43.9	75.3	136	132	0	30	30
2015	7	19	3	16	52	0.194	-0.016	0.889	0.039	0.036	0	46	44.3	75.3	137	133	0	30	30
2015	7	19	3	26	52	0.171	0.003	0.892	0.039	0.036	0	45.2	43.4	75.7	135	131	0	30	30
2015	7	19	3	36	52	0.21	-0.026	0.892	0.036	0.033	0	44.3	44.3	74.4	134	133	0	31	30
2015	7	19	3	46	52	0.223	-0.02	0.892	0.033	0.03	0	43.9	42.1	76.5	133	129	0	31	31
2015	7	19	3	56	52	0.22	0.003	0.892	0.039	0.036	0	45.2	43.9	76.5	136	132	0	31	30
2015	7	19	4	6	52	0.118	-0.039	0.892	0.039	0.036	0	44.3	43	76.1	133	130	0	30	30
2015	7	19	4	16	52	0.184	-0.039	0.892	0.033	0.03	0	43.9	43.9	75.7	133	131	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	19	4	26	52	0.21	0.003	0.892	0.039	0.036	0	44.3	43.4	75.7	134	131	0	31	30
2015	7	19	4	36	52	0.2	0.016	0.892	0.033	0.03	0	48.2	46.9	72.2	142	139	0	30	30
2015	7	19	4	46	52	0.213	-0.023	0.892	0.039	0.036	0	46	44.3	74.8	138	133	0	31	30
2015	7	19	4	56	52	0.246	-0.007	0.892	0.039	0.036	0	45.6	44.3	74.8	136	133	0	30	30
2015	7	19	5	6	52	0.233	-0.095	0.892	0.039	0.039	0	43.4	43	76.1	132	130	0	31	30
2015	7	19	5	16	52	0.167	-0.052	0.892	0.036	0.033	0	44.7	43.4	75.7	135	131	0	31	30
2015	7	19	5	26	52	0.203	-0.043	0.892	0.036	0.033	0	43.9	42.6	75.7	133	129	0	31	30
2015	7	19	5	36	52	0.194	0.026	0.892	0.033	0.03	0	43	43	75.3	131	130	0	31	30
2015	7	19	5	46	52	0.21	0.01	0.889	0.033	0.03	0	46.4	45.2	72.7	140	135	0	32	30
2015	7	19	5	56	52	0.272	-0.062	0.892	0.036	0.033	0	45.2	44.3	74.4	136	133	0	31	30
2015	7	19	6	6	52	0.279	-0.023	0.892	0.039	0.036	0	46.9	45.2	73.1	140	135	0	31	30
2015	7	19	6	16	52	0.203	-0.01	0.889	0.039	0.036	0	48.2	46.4	71.4	143	138	0	31	30
2015	7	19	6	26	52	0.18	-0.039	0.892	0.036	0.033	0	44.3	43	75.3	134	131	0	31	31
2015	7	19	6	36	52	0.167	0.016	0.892	0.036	0.033	0	41.7	42.1	76.5	128	128	0	31	30
2015	7	19	6	46	52	0.184	-0.02	0.892	0.036	0.033	0	42.6	41.7	77.4	130	127	0	31	30
2015	7	19	6	56	52	0.18	-0.023	0.892	0.039	0.039	0	42.6	43	76.1	130	130	0	31	30
2015	7	19	7	6	52	0.233	-0.085	0.892	0.033	0.03	0	43	41.7	76.5	130	127	0	30	30
2015	7	19	7	16	52	0.203	0.036	0.892	0.039	0.036	0	42.1	41.3	76.5	128	126	0	30	30
2015	7	19	7	26	52	0.128	-0.069	0.892	0.033	0.03	0	41.7	41.3	76.5	127	126	0	30	30
2015	7	19	7	36	52	0.213	-0.043	0.892	0.039	0.036	0	42.1	42.1	76.5	129	127	0	31	29
2015	7	19	7	46	52	0.18	-0.013	0.892	0.039	0.036	0	42.6	42.1	76.5	130	128	0	31	30
2015	7	19	7	56	52	0.167	-0.02	0.892	0.049	0.046	0	42.6	43	77.4	129	129	0	30	29
2015	7	19	8	6	52	0.223	0.013	0.892	0.039	0.036	0	42.1	42.1	77	129	128	0	31	30
2015	7	19	8	16	52	0.217	-0.013	0.892	0.036	0.033	0	44.7	43.4	75.3	135	131	0	31	30
2015	7	19	8	26	52	0.217	-0.01	0.892	0.036	0.033	0	44.3	43.9	75.7	134	132	0	31	30
2015	7	19	8	36	52	0.157	-0.036	0.892	0.039	0.036	0	43.9	43.9	76.5	133	132	0	31	30
2015	7	19	8	46	52	0.197	0.013	0.892	0.036	0.033	0	45.6	44.3	76.5	136	133	0	30	30
2015	7	19	8	56	52	0.187	-0.052	0.892	0.036	0.033	0	46	45.2	76.1	138	135	0	31	30
2015	7	19	9	6	52	0.2	0.066	0.892	0.033	0.03	0	45.2	45.2	75.7	136	135	0	31	30
2015	7	19	9	16	52	0.21	-0.02	0.892	0.036	0.033	0	46.9	46	75.3	140	136	0	31	29
2015	7	19	9	26	52	0.161	0.049	0.892	0.033	0.03	0	46.9	45.6	75.3	140	136	0	31	30
2015	7	19	9	36	52	0.184	0	0.892	0.039	0.039	0	47.7	46.4	75.7	142	137	0	31	29
2015	7	19	9	46	52	0.226	-0.016	0.892	0.033	0.03	0	46.9	47.3	74.4	140	140	0	31	30
2015	7	19	9	56	52	0.144	0.046	0.892	0.039	0.039	0	49.5	48.6	74	145	143	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	19	10	6	52	0.167	0.052	0.892	0.033	0.03	0	49.5	47.3	74.8	146	140	0	31	30
2015	7	19	10	16	52	0.125	0.036	0.892	0.033	0.03	0	48.6	49	73.1	144	144	0	31	30
2015	7	19	10	26	52	0.22	0.03	0.892	0.039	0.036	0	50.3	49.5	73.1	147	145	0	30	30
2015	7	19	10	36	52	0.236	-0.007	0.892	0.036	0.033	0	49.9	49.5	74	146	145	0	30	30
2015	7	19	10	46	52	0.066	0.003	0.892	0.033	0.03	0	49.5	51.2	74	146	149	0	31	30
2015	7	19	10	56	52	0.22	0.052	0.892	0.036	0.033	0	50.7	52	74.4	148	150	0	30	29
2015	7	19	11	6	52	0.115	-0.039	0.892	0.036	0.033	0	51.2	52	72.2	150	151	0	31	30
2015	7	19	11	16	52	0.144	-0.026	0.892	0.036	0.033	0	51.2	52	72.7	149	151	0	30	30
2015	7	19	11	26	52	0.18	0.092	0.889	0.033	0.03	0	52	53.8	71.4	152	155	0	31	30
2015	7	19	11	36	52	0.148	0.138	0.892	0.039	0.039	0	52.5	53.3	71.8	152	154	0	30	30
2015	7	19	11	46	52	0.154	0.02	0.889	0.039	0.039	0	52.5	53.3	71.4	152	154	0	30	30
2015	7	19	11	56	52	0.19	0.013	0.889	0.036	0.033	0	51.6	52.9	70.5	150	153	0	30	30
2015	7	19	12	6	52	0.167	0.062	0.889	0.039	0.036	0	54.2	55.9	67.5	156	159	0	30	29
2015	7	19	12	16	52	0.243	0.043	0.889	0.039	0.036	0	55.9	55.9	67.5	160	159	0	30	29
2015	7	19	12	26	52	0.21	0.066	0.889	0.036	0.033	0	55.5	55.5	67.5	159	159	0	30	30
2015	7	19	12	36	52	0.184	0.02	0.889	0.043	0.039	0	52.9	53.3	69.2	153	154	0	30	30
2015	7	19	12	46	52	0.154	0.052	0.889	0.036	0.033	0	51.2	51.6	71.4	149	150	0	30	30
2015	7	19	12	56	52	0.197	0.056	0.889	0.036	0.033	0	52.5	52.5	71.8	152	152	0	30	30
2015	7	19	13	6	52	0.118	0.095	0.889	0.036	0.033	0	54.2	53.8	68.8	156	155	0	30	30
2015	7	19	13	16	52	0.174	0.036	0.889	0.036	0.033	0	55	54.6	68.8	158	157	0	30	30
2015	7	19	13	26	52	0.174	0.092	0.889	0.036	0.033	0	57.6	57.6	65.4	165	164	0	31	30
2015	7	19	13	36	52	0.194	0.066	0.889	0.036	0.033	0	57.2	57.2	65.8	164	162	0	31	29
2015	7	19	13	46	52	0.197	0.079	0.889	0.033	0.03	0	56.8	57.6	65.4	163	163	0	31	29
2015	7	19	13	56	52	0.226	0.095	0.889	0.043	0.039	0	57.2	57.2	63.6	163	163	0	30	30
2015	7	19	14	6	52	0.259	0.062	0.889	0.033	0.03	0	56.8	57.2	64.5	163	163	0	31	30
2015	7	19	14	16	52	0.22	0.023	0.886	0.033	0.03	0	58	58	64.1	165	164	0	30	29
2015	7	19	14	26	52	0.171	0.056	0.889	0.036	0.033	0	58	57.6	62.4	165	164	0	30	30
2015	7	19	14	36	52	0.23	0.112	0.886	0.036	0.033	0	58	57.6	64.1	165	163	0	30	29
2015	7	19	14	46	52	0.18	0	0.889	0.036	0.033	0	56.8	55.9	64.5	162	159	0	30	29
2015	7	19	14	56	52	0.154	0	0.889	0.033	0.03	0	56.3	55.9	64.9	161	160	0	30	30
2015	7	19	15	6	52	0.194	0.092	0.889	0.036	0.033	0	54.6	53.8	66.7	157	154	0	30	29
2015	7	19	15	16	52	0.154	0.049	0.886	0.036	0.033	0	56.3	56.3	64.5	161	160	0	30	29
2015	7	19	15	26	52	0.18	0.148	0.886	0.033	0.03	0	58.5	57.2	63.2	166	162	0	30	29
2015	7	19	15	36	52	0.285	0.059	0.886	0.033	0.03	0	58.5	58	63.6	166	164	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	19	15	46	52	0.2	0.105	0.886	0.039	0.039	0	58	58	63.6	166	164	0	31	29
2015	7	19	15	56	52	0.19	0.075	0.886	0.036	0.033	0	57.6	57.2	64.9	164	163	0	30	30
2015	7	19	16	6	52	0.207	0.026	0.886	0.039	0.036	0	51.6	51.6	67.5	150	149	0	30	29
2015	7	19	16	16	52	0.187	0.036	0.883	0.046	0.043	0	55.5	55.5	63.6	159	158	0	30	29
2015	7	19	16	26	52	0.141	0	0.886	0.039	0.036	0	51.6	51.6	67.1	150	149	0	30	29
2015	7	19	16	36	52	0.223	-0.072	0.886	0.036	0.033	0	51.6	51.6	68.4	150	149	0	30	29
2015	7	19	16	46	52	0.217	0.066	0.886	0.046	0.043	0	50.7	49.5	68.4	148	145	0	30	30
2015	7	19	16	56	52	0.21	0.039	0.886	0.039	0.036	0	53.8	54.2	64.5	156	155	0	31	29
2015	7	19	17	6	52	0.161	0.02	0.886	0.036	0.033	0	50.3	49.9	68.8	147	145	0	30	29
2015	7	19	17	16	52	0.167	0.02	0.886	0.039	0.036	0	47.7	46.4	70.1	141	137	0	30	29
2015	7	19	17	26	52	0.19	0.003	0.886	0.043	0.039	0	49	47.7	67.1	144	140	0	30	29
2015	7	19	17	36	52	0.203	0.023	0.886	0.043	0.039	0	48.2	46.4	69.2	142	137	0	30	29
2015	7	19	17	46	52	0.187	0.052	0.883	0.039	0.039	0	50.3	49	65.8	147	143	0	30	29
2015	7	19	17	56	52	0.167	0.026	0.886	0.039	0.039	0	48.2	46	68.8	142	137	0	30	30
2015	7	19	18	6	52	0.184	-0.02	0.886	0.043	0.039	0	47.7	46.4	69.2	141	137	0	30	29
2015	7	19	18	16	52	0.203	0.007	0.883	0.033	0.03	0	48.6	47.3	68.4	143	139	0	30	29
2015	7	19	18	26	52	0.22	0.046	0.886	0.039	0.039	0	48.2	46.4	69.2	142	137	0	30	29
2015	7	19	18	36	52	0.249	-0.01	0.883	0.039	0.036	0	48.6	46.4	67.9	143	138	0	30	30
2015	7	19	18	46	52	0.174	0.01	0.886	0.039	0.036	0	46.9	45.2	71	139	134	0	30	29
2015	7	19	18	56	52	0.24	-0.02	0.886	0.036	0.033	0	46.9	45.2	70.5	139	135	0	30	30
2015	7	19	19	6	52	0.269	-0.059	0.883	0.043	0.039	0	49.5	47.3	67.9	145	140	0	30	30
2015	7	19	19	16	52	0.18	-0.052	0.886	0.039	0.039	0	47.7	46	69.7	141	136	0	30	29
2015	7	19	19	26	52	0.223	0.033	0.886	0.036	0.033	0	47.7	46	68.4	141	136	0	30	29
2015	7	19	19	36	52	0.269	-0.062	0.883	0.036	0.033	0	49.5	47.7	64.1	145	140	0	30	29
2015	7	19	19	46	52	0.138	0.026	0.883	0.033	0.03	0	50.3	48.2	63.2	147	141	0	30	29
2015	7	19	19	56	52	0.226	-0.066	0.879	0.039	0.036	0	50.3	48.6	64.5	147	142	0	30	29
2015	7	19	20	6	52	0.226	-0.013	0.883	0.036	0.033	0	48.6	47.3	67.5	144	139	0	31	29
2015	7	19	20	16	52	0.174	-0.023	0.886	0.036	0.033	0	48.2	46.9	69.7	143	139	0	31	30
2015	7	19	20	26	52	0.197	0.039	0.886	0.039	0.036	0	47.3	46	70.5	140	136	0	30	29
2015	7	19	20	36	52	0.226	0.036	0.886	0.039	0.036	0	47.7	46.4	71	141	137	0	30	29
2015	7	19	20	46	52	0.167	-0.089	0.886	0.039	0.036	0	49.5	48.6	67.9	145	142	0	30	29
2015	7	19	20	56	52	0.131	-0.075	0.886	0.039	0.036	0	49.9	48.6	66.7	146	142	0	30	29
2015	7	19	21	6	52	0.151	0.01	0.886	0.039	0.036	0	46.9	46	71	139	136	0	30	29
2015	7	19	21	16	52	0.174	-0.023	0.886	0.039	0.036	0	47.3	45.6	71	140	135	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	19	21	26	52	0.19	-0.069	0.886	0.036	0.033	0	47.7	46.9	69.7	142	138	0	31	29
2015	7	19	21	36	52	0.23	0	0.886	0.036	0.033	0	48.2	46.4	69.7	142	137	0	30	29
2015	7	19	21	46	52	0.233	-0.036	0.886	0.043	0.039	0	51.2	49	67.1	149	143	0	30	29
2015	7	19	21	56	52	0.21	-0.016	0.886	0.039	0.036	0	48.2	46.4	70.1	142	137	0	30	29
2015	7	19	22	6	52	0.171	-0.01	0.886	0.036	0.033	0	48.2	46.4	69.2	142	137	0	30	29
2015	7	19	22	16	52	0.079	-0.059	0.886	0.039	0.036	0	48.6	47.3	67.9	143	139	0	30	29
2015	7	19	22	26	52	0.226	-0.02	0.886	0.046	0.043	0	49	47.3	69.2	143	139	0	29	29
2015	7	19	22	36	52	0.259	-0.036	0.886	0.043	0.039	0	47.7	45.6	70.1	141	136	0	30	30
2015	7	19	22	46	52	0.187	-0.02	0.886	0.036	0.033	0	47.7	46	69.7	141	136	0	30	29
2015	7	19	22	56	52	0.276	0.013	0.886	0.039	0.039	0	46.9	45.2	72.2	139	135	0	30	30
2015	7	19	23	6	52	0.253	-0.007	0.886	0.036	0.033	0	47.3	45.6	71	140	135	0	30	29
2015	7	19	23	16	52	0.213	0.052	0.886	0.033	0.03	0	45.6	44.3	72.2	136	132	0	30	29
2015	7	19	23	26	52	0.102	-0.007	0.886	0.039	0.036	0	46	44.3	72.2	137	132	0	30	29
2015	7	19	23	36	52	0.121	-0.039	0.883	0.039	0.039	0	51.6	49.5	61.5	150	145	0	30	30
2015	7	19	23	46	52	0.2	0.075	0.886	0.036	0.033	0	56.3	54.6	61.1	161	156	0	30	29
2015	7	19	23	56	52	0.295	0.121	0.886	0.039	0.036	0	55.5	54.2	61.5	160	156	0	31	30
2015	7	20	0	6	52	0.233	0.082	0.886	0.043	0.039	0	57.2	55.5	60.2	163	159	0	30	30
2015	7	20	0	16	52	0.2	0.082	0.886	0.033	0.03	0	55.9	53.8	62.4	161	155	0	31	30
2015	7	20	0	26	52	0.148	0.062	0.886	0.039	0.039	0	55.5	53.8	63.2	159	154	0	30	29
2015	7	20	0	36	52	0.187	0.102	0.886	0.039	0.036	0	53.3	52	65.4	154	150	0	30	29
2015	7	20	0	46	52	0.187	0.108	0.886	0.039	0.039	0	52.9	51.2	64.5	153	149	0	30	30
2015	7	20	0	56	52	0.2	0.112	0.886	0.033	0.03	0	52.5	52	64.5	153	150	0	31	29
2015	7	20	1	6	52	0.213	0.141	0.886	0.036	0.033	0	53.3	51.2	64.9	154	148	0	30	29
2015	7	20	1	16	52	0.243	0.194	0.886	0.039	0.039	0	52.9	51.2	64.1	153	149	0	30	30
2015	7	20	1	26	52	0.24	0.167	0.886	0.039	0.039	0	53.3	52	62.4	154	150	0	30	29
2015	7	20	1	36	52	0.128	0.052	0.886	0.039	0.039	0	54.6	52.5	64.1	157	152	0	30	30
2015	7	20	1	46	52	0.236	0.052	0.886	0.039	0.039	0	54.2	52.9	63.2	156	153	0	30	30
2015	7	20	1	56	52	0.203	0.118	0.889	0.039	0.036	0	54.2	52	64.5	156	151	0	30	30
2015	7	20	2	6	52	0.21	0.161	0.886	0.043	0.039	0	53.8	52	64.9	155	150	0	30	29
2015	7	20	2	16	52	0.308	0.19	0.889	0.039	0.036	0	52.5	51.2	64.5	153	148	0	31	29
2015	7	20	2	26	52	0.19	0.292	0.889	0.039	0.039	0	52.9	51.6	65.4	153	149	0	30	29
2015	7	20	2	36	52	0.23	0.24	0.889	0.039	0.036	0	53.3	52	65.4	154	150	0	30	29
2015	7	20	2	46	52	0.338	0.282	0.889	0.036	0.033	0	53.3	51.6	65.4	155	150	0	31	30
2015	7	20	2	56	52	0.302	0.344	0.889	0.043	0.039	0	53.8	52	64.9	155	150	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	20	3	6	52	0.285	0.253	0.889	0.043	0.039	0	53.8	52	65.4	155	150	0	30	29
2015	7	20	3	16	52	0.246	0.269	0.889	0.039	0.039	0	53.3	52	64.9	155	150	0	31	29
2015	7	20	3	26	52	0.22	0.394	0.889	0.039	0.039	0	53.3	51.6	65.4	155	150	0	31	30
2015	7	20	3	36	52	0.295	0.295	0.889	0.046	0.046	0	53.3	51.2	66.2	154	149	0	30	30
2015	7	20	3	46	52	0.18	0.371	0.889	0.046	0.043	0	53.3	50.7	66.2	154	148	0	30	30
2015	7	20	3	56	52	0.259	0.371	0.889	0.036	0.033	0	52.9	51.2	66.2	153	148	0	30	29
2015	7	20	4	6	52	0.249	0.272	0.889	0.046	0.043	0	52.5	50.7	66.7	153	148	0	31	30
2015	7	20	4	16	52	0.253	0.312	0.889	0.039	0.036	0	52.9	51.6	66.2	153	149	0	30	29
2015	7	20	4	26	52	0.197	0.318	0.889	0.039	0.039	0	52.5	50.7	66.7	153	148	0	31	30
2015	7	20	4	36	52	0.226	0.4	0.889	0.036	0.033	0	52.5	50.7	67.1	152	147	0	30	29
2015	7	20	4	46	52	0.197	0.331	0.889	0.039	0.036	0	52	50.7	66.7	152	147	0	31	29
2015	7	20	4	56	52	0.187	0.256	0.889	0.039	0.036	0	52.9	50.7	66.7	153	148	0	30	30
2015	7	20	5	6	52	0.295	0.325	0.889	0.039	0.039	0	52.5	50.7	67.5	152	147	0	30	29
2015	7	20	5	16	52	0.184	0.358	0.889	0.039	0.039	0	51.6	49.5	67.9	150	145	0	30	30
2015	7	20	5	26	52	0.295	0.325	0.889	0.036	0.033	0	50.7	49.5	68.8	149	144	0	31	29
2015	7	20	5	36	52	0.184	0.259	0.889	0.033	0.03	0	49.9	48.2	69.7	147	142	0	31	30
2015	7	20	5	46	52	0.22	0.256	0.892	0.039	0.036	0	49.9	48.6	69.2	147	143	0	31	30
2015	7	20	5	56	52	0.24	0.269	0.892	0.033	0.03	0	48.6	47.7	70.5	144	140	0	31	29
2015	7	20	6	6	52	0.279	0.213	0.892	0.039	0.036	0	47.7	47.3	71.4	142	139	0	31	29
2015	7	20	6	16	52	0.302	0.223	0.892	0.043	0.039	0	48.2	46.4	71.8	142	138	0	30	30
2015	7	20	6	26	52	0.253	0.24	0.892	0.039	0.039	0	46.4	45.6	72.7	139	136	0	31	30
2015	7	20	6	36	52	0.24	0.174	0.892	0.039	0.036	0	47.7	46	73.1	141	137	0	30	30
2015	7	20	6	46	52	0.246	0.167	0.892	0.039	0.039	0	46.9	45.6	73.1	139	136	0	30	30
2015	7	20	6	56	52	0.22	0.075	0.892	0.046	0.043	0	46	45.2	73.5	138	134	0	31	29
2015	7	20	7	6	52	0.23	0.118	0.892	0.039	0.036	0	48.2	47.3	72.7	142	139	0	30	29
2015	7	20	7	16	52	0.174	0.125	0.892	0.033	0.03	0	46.4	44.7	74.8	139	134	0	31	30
2015	7	20	7	26	52	0.233	0.069	0.892	0.039	0.036	0	45.6	44.7	74.8	137	134	0	31	30
2015	7	20	7	36	52	0.226	0.098	0.892	0.036	0.033	0	45.6	44.3	74.4	137	133	0	31	30
2015	7	20	7	46	52	0.157	0	0.892	0.036	0.033	0	49	47.3	71	145	140	0	31	30
2015	7	20	7	56	52	0.226	-0.016	0.892	0.039	0.039	0	46	43.9	76.1	137	132	0	30	30
2015	7	20	8	6	52	0.197	0.03	0.892	0.036	0.033	0	46.9	44.3	74.4	139	134	0	30	31
2015	7	20	8	16	52	0.164	-0.02	0.892	0.033	0.03	0	47.7	46	72.7	141	137	0	30	30
2015	7	20	8	26	52	0.18	0	0.892	0.039	0.036	0	45.6	44.7	75.3	137	133	0	31	29
2015	7	20	8	36	52	0.197	0.007	0.892	0.036	0.033	0	46.9	46.4	74	140	137	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	20	8	46	52	0.164	-0.013	0.892	0.039	0.036	0	46.9	46.9	74.8	139	138	0	30	29
2015	7	20	8	56	52	0.184	0.036	0.892	0.036	0.033	0	49	47.7	73.1	145	141	0	31	30
2015	7	20	9	6	52	0.2	0.056	0.896	0.039	0.036	0	47.7	47.7	73.1	142	141	0	31	30
2015	7	20	9	16	52	0.18	0.095	0.892	0.039	0.036	0	49	47.7	73.5	144	141	0	30	30
2015	7	20	9	26	52	0.24	-0.007	0.896	0.036	0.033	0	48.2	47.3	74.4	143	140	0	31	30
2015	7	20	9	36	52	0.233	-0.01	0.896	0.033	0.03	0	48.6	47.7	73.1	143	140	0	30	29
2015	7	20	9	46	52	0.148	0.033	0.896	0.033	0.03	0	47.3	47.3	75.3	140	140	0	30	30
2015	7	20	9	56	52	0.203	-0.003	0.896	0.033	0.03	0	49.5	48.2	73.5	145	142	0	30	30
2015	7	20	10	6	52	0.217	0.089	0.892	0.039	0.036	0	52	51.6	69.7	152	149	0	31	29
2015	7	20	10	16	52	0.213	0.056	0.892	0.033	0.03	0	50.3	49	71.4	147	144	0	30	30
2015	7	20	10	26	52	0.19	0.03	0.896	0.039	0.036	0	49.5	47.7	73.1	145	141	0	30	30
2015	7	20	10	36	52	0.23	0.062	0.896	0.043	0.039	0	48.2	47.7	74.4	142	139	0	30	28
2015	7	20	10	46	52	0.259	0.016	0.896	0.033	0.03	0	47.7	47.7	73.5	142	141	0	31	30
2015	7	20	10	56	52	0.259	0.056	0.896	0.039	0.036	0	49.5	47.7	73.5	145	141	0	30	30
2015	7	20	11	6	52	0.161	0.056	0.896	0.039	0.036	0	49.5	50.3	72.2	145	146	0	30	29
2015	7	20	11	16	52	0.171	0.049	0.896	0.039	0.036	0	50.3	49.9	72.2	148	146	0	31	30
2015	7	20	11	26	52	0.177	0.01	0.896	0.033	0.03	0	52	52.5	71	152	151	0	31	29
2015	7	20	11	36	52	0.151	-0.079	0.896	0.039	0.036	0	53.8	52.9	68.8	156	153	0	31	30
2015	7	20	11	46	52	0.131	0.033	0.896	0.036	0.033	0	55	54.2	68.4	158	156	0	30	30
2015	7	20	11	56	52	0.213	0.046	0.896	0.039	0.036	0	54.6	53.8	68.4	157	155	0	30	30
2015	7	20	12	6	52	0.19	0.069	0.896	0.036	0.033	0	53.3	53.8	70.1	155	154	0	31	29
2015	7	20	12	16	52	0.22	0.056	0.896	0.039	0.036	0	56.3	55	67.9	160	158	0	29	30
2015	7	20	12	26	52	0.223	0.036	0.896	0.039	0.036	0	54.6	54.6	70.1	157	156	0	30	29
2015	7	20	12	36	52	0.18	0.056	0.896	0.036	0.033	0	55	54.6	69.2	158	156	0	30	29
2015	7	20	12	46	52	0.194	0.059	0.896	0.036	0.033	0	55	54.2	70.5	158	156	0	30	30
2015	7	20	12	56	52	0.177	0.138	0.896	0.039	0.036	0	55	55.5	70.5	158	158	0	30	29
2015	7	20	13	6	52	0.2	0.072	0.896	0.036	0.033	0	55.5	55.5	69.2	160	159	0	31	30
2015	7	20	13	16	52	0.2	0.072	0.896	0.036	0.033	0	54.2	54.6	68.4	157	157	0	31	30
2015	7	20	13	26	52	0.207	0.062	0.896	0.039	0.039	0	53.8	54.2	70.1	156	155	0	31	29
2015	7	20	13	36	52	0.203	0.039	0.896	0.036	0.033	0	53.3	53.3	71	155	154	0	31	30
2015	7	20	13	46	52	0.2	-0.056	0.896	0.033	0.03	0	50.3	50.7	74	148	148	0	31	30
2015	7	20	13	56	52	0.154	0.036	0.896	0.039	0.036	0	49.5	49.5	72.7	146	145	0	31	30
2015	7	20	14	6	52	0.167	0.036	0.896	0.039	0.036	0	51.6	50.7	71.8	150	148	0	30	30
2015	7	20	14	16	52	0.131	0.092	0.896	0.039	0.036	0	52	52	70.5	151	150	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	20	14	26	52	0.213	0.03	0.896	0.033	0.03	0	51.2	50.3	72.2	149	146	0	30	29
2015	7	20	14	36	52	0.148	-0.01	0.896	0.036	0.033	0	50.7	50.7	72.7	149	148	0	31	30
2015	7	20	14	46	52	0.197	0.125	0.896	0.033	0.03	0	52.9	52	71.4	153	150	0	30	29
2015	7	20	14	56	52	0.279	0.02	0.896	0.039	0.036	0	54.2	53.3	70.1	156	154	0	30	30
2015	7	20	15	6	52	0.266	0.059	0.896	0.036	0.033	0	55	54.2	68.8	159	156	0	31	30
2015	7	20	15	16	52	0.164	0.046	0.896	0.036	0.033	0	52.9	53.3	71	153	153	0	30	29
2015	7	20	15	26	52	0.217	-0.003	0.896	0.046	0.043	0	50.3	49.9	72.7	147	145	0	30	29
2015	7	20	15	36	52	0.18	0.079	0.892	0.049	0.046	0	49	49	71.4	145	144	0	31	30
2015	7	20	15	46	52	0.233	0.033	0.896	0.033	0.03	0	49	48.2	72.7	144	141	0	30	29
2015	7	20	15	56	52	0.217	0.089	0.896	0.043	0.039	0	48.6	49	74	144	143	0	31	29
2015	7	20	16	6	52	0.23	0.062	0.896	0.039	0.036	0	49	48.6	72.7	145	143	0	31	30
2015	7	20	16	16	52	0.148	0.079	0.896	0.036	0.033	0	50.3	49.5	74.4	147	144	0	30	29
2015	7	20	16	26	52	0.2	0.026	0.896	0.039	0.036	0	49.9	48.6	74.4	146	142	0	30	29
2015	7	20	16	36	52	0.187	0.069	0.896	0.033	0.03	0	49.9	49.5	73.5	146	144	0	30	29
2015	7	20	16	46	52	0.233	0.092	0.896	0.039	0.036	0	52	50.3	72.2	151	147	0	30	30
2015	7	20	16	56	52	0.226	-0.023	0.896	0.039	0.036	0	52.5	51.6	70.1	152	149	0	30	29
2015	7	20	17	6	52	0.187	0.036	0.896	0.043	0.039	0	50.7	49.5	70.5	148	145	0	30	30
2015	7	20	17	16	52	0.256	0.075	0.896	0.043	0.039	0	51.6	50.3	70.1	150	147	0	30	30
2015	7	20	17	26	52	0.19	0.062	0.896	0.033	0.03	0	51.2	49.5	71.4	149	145	0	30	30
2015	7	20	17	36	52	0.213	0.03	0.896	0.039	0.036	0	51.2	52	71	150	150	0	31	29
2015	7	20	17	46	52	0.164	0.079	0.896	0.033	0.03	0	52.9	52.9	70.1	153	152	0	30	29
2015	7	20	17	56	52	0.194	0.01	0.896	0.039	0.039	0	50.3	50.7	72.2	147	147	0	30	29
2015	7	20	18	6	52	0.187	0.049	0.896	0.039	0.036	0	48.2	48.2	73.1	143	142	0	31	30
2015	7	20	18	16	52	0.121	0.026	0.896	0.039	0.036	0	49	49	72.7	144	143	0	30	29
2015	7	20	18	26	52	0.233	0.066	0.896	0.036	0.033	0	49.9	48.6	72.2	146	142	0	30	29
2015	7	20	18	36	52	0.177	0.036	0.896	0.039	0.036	0	51.6	50.3	70.5	150	146	0	30	29
2015	7	20	18	46	52	0.171	0.026	0.889	0.046	0.043	0	54.6	52.9	63.2	157	152	0	30	29
2015	7	20	18	56	52	0.282	0.072	0.896	0.039	0.036	0	54.6	52.5	66.2	157	152	0	30	30
2015	7	20	19	6	52	0.23	0.128	0.896	0.046	0.043	0	53.3	52.5	67.9	154	151	0	30	29
2015	7	20	19	16	52	0.217	0.105	0.896	0.039	0.036	0	52.9	51.6	68.4	153	149	0	30	29
2015	7	20	19	26	52	0.203	0.112	0.896	0.043	0.039	0	52	50.7	68.4	151	148	0	30	30
2015	7	20	19	36	52	0.203	0.062	0.896	0.039	0.036	0	51.2	49.5	70.5	149	144	0	30	29
2015	7	20	19	46	52	0.312	0.049	0.896	0.033	0.03	0	50.7	49	70.5	148	144	0	30	30
2015	7	20	19	56	52	0.217	0.033	0.896	0.036	0.033	0	50.3	48.2	70.1	147	142	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	20	20	6	52	0.194	0.098	0.896	0.039	0.039	0	49.5	47.7	71.8	145	140	0	30	29
2015	7	20	20	16	52	0.21	-0.043	0.896	0.039	0.036	0	52.9	51.6	67.9	153	149	0	30	29
2015	7	20	20	26	52	0.226	-0.066	0.896	0.056	0.052	0	49.5	48.6	71	146	142	0	31	29
2015	7	20	20	36	52	0.217	0.01	0.896	0.036	0.033	0	51.2	49.9	69.7	150	145	0	31	29
2015	7	20	20	46	52	0.226	0.039	0.896	0.039	0.036	0	49	47.7	72.7	144	140	0	30	29
2015	7	20	20	56	52	0.24	0.01	0.896	0.039	0.039	0	49.9	47.7	71.8	146	140	0	30	29
2015	7	20	21	6	52	0.174	0	0.896	0.046	0.043	0	50.3	48.6	70.5	148	142	0	31	29
2015	7	20	21	16	52	0.282	0.013	0.896	0.036	0.033	0	48.6	46.9	72.7	143	138	0	30	29
2015	7	20	21	26	52	0.148	0.069	0.896	0.039	0.039	0	49.9	47.7	71	146	141	0	30	30
2015	7	20	21	36	52	0.184	0.059	0.896	0.043	0.039	0	49	46.9	71.8	144	139	0	30	30
2015	7	20	21	46	52	0.24	0.026	0.896	0.039	0.036	0	48.2	46	72.7	142	137	0	30	30
2015	7	20	21	56	52	0.207	0	0.896	0.039	0.036	0	48.6	46.9	71.8	143	138	0	30	29
2015	7	20	22	6	52	0.226	0.02	0.896	0.043	0.039	0	51.2	49.5	66.2	149	144	0	30	29
2015	7	20	22	16	52	0.276	0.023	0.896	0.039	0.039	0	51.2	49.9	64.9	149	145	0	30	29
2015	7	20	22	26	52	0.19	-0.02	0.896	0.036	0.033	0	52	49.9	67.1	150	145	0	29	29
2015	7	20	22	36	52	0.243	0	0.896	0.039	0.036	0	50.7	49.5	67.1	148	144	0	30	29
2015	7	20	22	46	52	0.24	-0.01	0.896	0.039	0.039	0	50.3	49	68.8	148	143	0	31	29
2015	7	20	22	56	52	0.131	-0.089	0.896	0.039	0.036	0	50.3	48.6	69.2	148	142	0	31	29
2015	7	20	23	6	52	0.243	-0.02	0.896	0.033	0.03	0	47.7	46.9	72.2	141	139	0	30	30
2015	7	20	23	16	52	0.24	0.043	0.896	0.039	0.036	0	48.2	46.4	72.7	142	137	0	30	29
2015	7	20	23	26	52	0.22	0.023	0.896	0.036	0.033	0	47.3	46.4	72.7	141	137	0	31	29
2015	7	20	23	36	52	0.236	-0.056	0.896	0.036	0.033	0	47.3	45.6	73.5	140	135	0	30	29
2015	7	20	23	46	52	0.187	-0.049	0.896	0.039	0.036	0	46.4	44.3	74.4	138	133	0	30	30
2015	7	20	23	56	52	0.236	-0.03	0.896	0.043	0.039	0	46.4	45.2	72.7	139	134	0	31	29
2015	7	21	0	6	52	0.223	0.036	0.896	0.039	0.036	0	45.6	44.3	74.8	136	132	0	30	29
2015	7	21	0	16	52	0.164	-0.03	0.899	0.043	0.039	0	46	44.7	74	137	133	0	30	29
2015	7	21	0	26	52	0.164	0.007	0.899	0.039	0.039	0	46.9	44.7	74.4	139	134	0	30	30
2015	7	21	0	36	52	0.203	0.016	0.896	0.039	0.036	0	45.6	44.3	74.4	137	132	0	31	29
2015	7	21	0	46	52	0.24	-0.036	0.896	0.033	0.03	0	46	44.3	74	137	132	0	30	29
2015	7	21	0	56	52	0.233	0.016	0.899	0.036	0.033	0	45.6	45.2	74.4	136	133	0	30	28
2015	7	21	1	6	52	0.24	0.013	0.896	0.039	0.036	0	46.9	45.6	73.5	140	136	0	31	30
2015	7	21	1	16	52	0.22	-0.016	0.896	0.033	0.03	0	45.6	44.3	74	136	133	0	30	30
2015	7	21	1	26	52	0.213	-0.046	0.899	0.033	0.03	0	45.2	43.4	75.7	134	131	0	29	30
2015	7	21	1	36	52	0.233	0	0.896	0.036	0.033	0	46.4	44.3	73.5	138	133	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	21	1	46	52	0.177	0	0.896	0.043	0.039	0	44.7	44.3	74	135	133	0	31	30
2015	7	21	1	56	52	0.223	0	0.896	0.039	0.036	0	46.4	44.7	73.5	138	133	0	30	29
2015	7	21	2	6	52	0.141	0.03	0.896	0.036	0.033	0	46.4	45.6	73.5	139	136	0	31	30
2015	7	21	2	16	52	0.184	-0.016	0.896	0.052	0.052	0	45.6	43.9	74.4	137	132	0	31	30
2015	7	21	2	26	52	0.226	-0.026	0.899	0.039	0.039	0	45.6	43.9	74.8	136	132	0	30	30
2015	7	21	2	36	52	0.256	-0.033	0.896	0.036	0.033	0	45.2	44.3	74.8	135	132	0	30	29
2015	7	21	2	46	52	0.184	-0.01	0.896	0.036	0.033	0	45.6	43.9	74.8	136	132	0	30	30
2015	7	21	2	56	52	0.217	-0.01	0.896	0.039	0.036	0	44.7	43.9	74.8	135	132	0	31	30
2015	7	21	3	6	52	0.23	-0.013	0.896	0.049	0.049	0	45.2	44.3	74.8	135	132	0	30	29
2015	7	21	3	16	52	0.174	0.016	0.896	0.036	0.033	0	44.7	43.4	75.7	134	131	0	30	30
2015	7	21	3	26	52	0.24	0.016	0.896	0.039	0.039	0	44.7	43.9	74	135	132	0	31	30
2015	7	21	3	36	52	0.23	-0.036	0.896	0.033	0.03	0	46	44.7	73.5	137	133	0	30	29
2015	7	21	3	46	52	0.21	0	0.896	0.043	0.039	0	46	45.2	73.5	138	134	0	31	29
2015	7	21	3	56	52	0.194	-0.01	0.896	0.036	0.033	0	45.2	43.9	74.4	135	132	0	30	30
2015	7	21	4	6	52	0.164	0	0.896	0.033	0.03	0	45.6	44.3	73.5	136	133	0	30	30
2015	7	21	4	16	52	0.233	-0.043	0.896	0.033	0.03	0	46	44.3	74.4	137	133	0	30	30
2015	7	21	4	26	52	0.226	0	0.896	0.039	0.036	0	45.6	44.3	74.4	137	133	0	31	30
2015	7	21	4	36	52	0.161	-0.082	0.896	0.039	0.036	0	45.6	44.3	74.4	136	132	0	30	29
2015	7	21	4	46	52	0.184	-0.013	0.896	0.039	0.036	0	45.6	43.9	74.4	136	132	0	30	30
2015	7	21	4	56	52	0.22	-0.036	0.896	0.033	0.03	0	45.2	43.9	74.4	135	132	0	30	30
2015	7	21	5	6	52	0.197	-0.023	0.896	0.039	0.036	0	45.6	43.4	74.4	136	131	0	30	30
2015	7	21	5	16	52	0.213	-0.046	0.896	0.033	0.03	0	46.4	44.7	73.5	138	134	0	30	30
2015	7	21	5	26	52	0.164	-0.016	0.896	0.039	0.036	0	45.6	44.7	74	137	134	0	31	30
2015	7	21	5	36	52	0.187	-0.098	0.896	0.043	0.039	0	47.7	46.9	71.8	142	138	0	31	29
2015	7	21	5	46	52	0.207	-0.085	0.896	0.039	0.039	0	47.3	46.9	71.4	141	138	0	31	29
2015	7	21	5	56	52	0.171	-0.026	0.896	0.036	0.033	0	46	45.2	73.1	138	135	0	31	30
2015	7	21	6	6	52	0.184	-0.007	0.896	0.036	0.033	0	46	44.7	73.5	138	134	0	31	30
2015	7	21	6	16	52	0.233	-0.098	0.896	0.039	0.039	0	45.6	44.3	74	137	133	0	31	30
2015	7	21	6	26	52	0.203	-0.026	0.896	0.036	0.033	0	45.2	44.7	74.8	135	134	0	30	30
2015	7	21	6	36	52	0.18	-0.013	0.896	0.043	0.039	0	45.2	44.3	74.4	136	133	0	31	30
2015	7	21	6	46	52	0.197	0.016	0.896	0.036	0.033	0	44.3	43.4	74.8	134	131	0	31	30
2015	7	21	6	56	52	0.135	0.046	0.896	0.036	0.033	0	43.9	43.4	75.3	132	130	0	30	29
2015	7	21	7	6	52	0.187	-0.016	0.896	0.033	0.03	0	43	43	75.7	130	130	0	30	30
2015	7	21	7	16	52	0.233	-0.016	0.896	0.043	0.039	0	43.9	43	75.7	132	130	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	21	7	26	52	0.164	-0.036	0.896	0.033	0.03	0	44.7	43	74.8	135	131	0	31	31
2015	7	21	7	36	52	0.2	-0.026	0.896	0.046	0.043	0	45.2	44.7	74.8	136	133	0	31	29
2015	7	21	7	46	52	0.213	-0.039	0.896	0.036	0.033	0	43	42.6	77	131	129	0	31	30
2015	7	21	7	56	52	0.115	0.026	0.896	0.033	0.03	0	43.4	42.6	76.5	131	129	0	30	30
2015	7	21	8	6	52	0.2	-0.023	0.896	0.039	0.036	0	43.9	42.6	76.5	133	129	0	31	30
2015	7	21	8	16	52	0.148	-0.033	0.896	0.039	0.039	0	43.9	42.6	76.5	133	129	0	31	30
2015	7	21	8	26	52	0.203	-0.033	0.896	0.036	0.033	0	44.7	44.3	76.1	134	133	0	30	30
2015	7	21	8	36	52	0.207	0.033	0.896	0.033	0.03	0	45.2	44.7	75.3	136	133	0	31	29
2015	7	21	8	46	52	0.18	-0.023	0.896	0.036	0.033	0	45.2	44.7	76.1	136	134	0	31	30
2015	7	21	8	56	52	0.23	-0.02	0.896	0.036	0.033	0	45.2	45.2	74.8	136	135	0	31	30
2015	7	21	9	6	52	0.151	0	0.896	0.036	0.033	0	46.9	46	75.7	139	137	0	30	30
2015	7	21	9	16	52	0.157	0.033	0.896	0.033	0.03	0	47.7	47.3	74.4	142	140	0	31	30
2015	7	21	9	26	52	0.184	0.046	0.896	0.033	0.03	0	46.9	46.4	74.8	140	138	0	31	30
2015	7	21	9	36	52	0.203	-0.02	0.896	0.036	0.033	0	47.7	46.4	74.4	142	138	0	31	30
2015	7	21	9	46	52	0.207	-0.02	0.896	0.033	0.03	0	49	47.3	74	144	139	0	30	29
2015	7	21	9	56	52	0.246	0.03	0.896	0.033	0.03	0	47.7	49	73.5	142	144	0	31	30
2015	7	21	10	6	52	0.164	0.036	0.896	0.033	0.03	0	49.5	49	74	145	144	0	30	30
2015	7	21	10	16	52	0.203	0.046	0.896	0.033	0.03	0	49.5	49.5	74	146	145	0	31	30
2015	7	21	10	26	52	0.2	0.007	0.896	0.033	0.03	0	49.5	49	74	145	143	0	30	29
2015	7	21	10	36	52	0.226	0.075	0.896	0.036	0.033	0	49	50.3	73.1	145	147	0	31	30
2015	7	21	10	46	52	0.167	0.01	0.896	0.033	0.03	0	51.2	50.3	73.5	150	147	0	31	30
2015	7	21	10	56	52	0.236	0	0.896	0.033	0.03	0	49.9	51.6	72.7	146	149	0	30	29
2015	7	21	11	6	52	0.154	0.052	0.896	0.033	0.03	0	50.3	51.2	72.2	148	149	0	31	30
2015	7	21	11	16	52	0.223	0.036	0.892	0.033	0.03	0	50.7	52.5	73.5	149	151	0	31	29
2015	7	21	11	26	52	0.217	0.059	0.892	0.033	0.03	0	51.6	52.5	72.2	151	152	0	31	30
2015	7	21	11	36	52	0.171	0.089	0.892	0.033	0.03	0	52.9	52.9	71.8	153	153	0	30	30
2015	7	21	11	46	52	0.092	0.092	0.892	0.033	0.03	0	52	52.9	70.5	151	153	0	30	30
2015	7	21	11	56	52	0.24	0.059	0.892	0.039	0.036	0	52	53.8	71	152	154	0	31	29
2015	7	21	12	6	52	0.154	0.003	0.892	0.033	0.03	0	52.9	54.2	70.5	153	156	0	30	30
2015	7	21	12	16	52	0.236	0.03	0.892	0.036	0.033	0	52.9	54.2	69.2	154	155	0	31	29
2015	7	21	12	26	52	0.138	0.033	0.892	0.033	0.03	0	55	54.6	68.4	158	157	0	30	30
2015	7	21	12	36	52	0.138	0.066	0.892	0.036	0.033	0	54.6	54.6	67.1	157	157	0	30	30
2015	7	21	12	46	52	0.256	0.092	0.889	0.036	0.033	0	55.5	55.5	67.1	159	159	0	30	30
2015	7	21	12	56	52	0.21	0.026	0.892	0.033	0.03	0	55.5	55.5	66.2	160	159	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	21	13	6	52	0.203	-0.02	0.889	0.036	0.033	0	55.5	55.5	67.1	160	159	0	31	30
2015	7	21	13	16	52	0.19	0.092	0.892	0.036	0.033	0	55	55.9	66.7	158	160	0	30	30
2015	7	21	13	26	52	0.233	0.056	0.892	0.039	0.036	0	55	55.9	65.4	158	160	0	30	30
2015	7	21	13	36	52	0.217	0.075	0.892	0.033	0.03	0	55.9	56.3	65.4	160	160	0	30	29
2015	7	21	13	46	52	0.18	0.023	0.892	0.036	0.033	0	56.3	55.9	66.7	161	160	0	30	30
2015	7	21	13	56	52	0.2	0.056	0.889	0.039	0.036	0	55.5	56.3	64.9	159	160	0	30	29
2015	7	21	14	6	52	0.19	0.056	0.889	0.039	0.036	0	55.9	56.8	65.4	160	160	0	30	28
2015	7	21	14	16	52	0.223	0.121	0.889	0.039	0.036	0	55.5	56.3	66.2	159	160	0	30	29
2015	7	21	14	26	52	0.177	0.066	0.892	0.033	0.03	0	56.3	56.8	64.5	161	161	0	30	29
2015	7	21	14	36	52	0.217	0.115	0.889	0.036	0.033	0	56.8	55.5	64.9	162	159	0	30	30
2015	7	21	14	46	52	0.171	0.056	0.889	0.039	0.039	0	55	56.3	64.9	159	161	0	31	30
2015	7	21	14	56	52	0.164	0.056	0.889	0.033	0.03	0	54.6	55.9	64.9	158	159	0	31	29
2015	7	21	15	6	52	0.259	0.118	0.889	0.036	0.033	0	55	56.8	64.5	158	161	0	30	29
2015	7	21	15	16	52	0.18	0	0.889	0.039	0.036	0	52	53.8	67.5	151	154	0	30	29
2015	7	21	15	26	52	0.19	-0.003	0.889	0.043	0.039	0	47.7	48.6	70.5	141	142	0	30	29
2015	7	21	15	36	52	0.125	0.036	0.889	0.039	0.039	0	52	51.2	67.1	151	148	0	30	29
2015	7	21	15	46	52	0.18	-0.115	0.889	0.033	0.03	0	50.7	48.6	69.2	148	142	0	30	29
2015	7	21	15	56	52	0.164	0.036	0.889	0.043	0.039	0	50.7	48.2	69.2	148	142	0	30	30
2015	7	21	16	6	52	0.128	0.016	0.889	0.036	0.033	0	49.5	48.2	71	145	141	0	30	29
2015	7	21	16	16	52	0.171	0.039	0.889	0.039	0.036	0	51.2	49.9	68.4	149	145	0	30	29
2015	7	21	16	26	52	0.148	0.039	0.889	0.039	0.036	0	49.5	48.6	70.5	145	142	0	30	29
2015	7	21	16	36	52	0.177	0.02	0.889	0.039	0.036	0	49.5	49	68.8	145	143	0	30	29
2015	7	21	16	46	52	0.19	0.003	0.889	0.039	0.036	0	48.2	46.9	69.2	142	139	0	30	30
2015	7	21	16	56	52	0.167	0.033	0.889	0.039	0.039	0	46.4	45.6	71.4	138	135	0	30	29
2015	7	21	17	6	52	0.151	0.033	0.889	0.039	0.039	0	45.2	44.3	72.2	135	132	0	30	29
2015	7	21	17	16	52	0.249	-0.013	0.889	0.039	0.036	0	46.4	44.7	70.5	138	133	0	30	29
2015	7	21	17	26	52	0.174	-0.01	0.889	0.033	0.03	0	44.7	43	73.1	134	130	0	30	30
2015	7	21	17	36	52	0.131	0.052	0.889	0.033	0.03	0	47.3	44.3	70.5	140	133	0	30	30
2015	7	21	17	46	52	0.177	-0.033	0.886	0.043	0.043	0	48.2	46.4	67.1	142	137	0	30	29
2015	7	21	17	56	52	0.249	0.049	0.886	0.036	0.033	0	49.5	47.7	65.4	145	140	0	30	29
2015	7	21	18	6	52	0.24	0.033	0.886	0.033	0.03	0	49.5	47.3	67.5	145	139	0	30	29
2015	7	21	18	16	52	0.19	-0.01	0.883	0.033	0.03	0	48.2	47.3	65.4	143	139	0	31	29
2015	7	21	18	26	52	0.243	0.013	0.889	0.033	0.03	0	47.7	46.4	70.1	141	137	0	30	29
2015	7	21	18	36	52	0.22	0.013	0.889	0.036	0.033	0	46.9	45.6	71	139	135	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	21	18	46	52	0.194	0.075	0.889	0.036	0.033	0	46.4	44.3	71	139	133	0	31	30
2015	7	21	18	56	52	0.226	0	0.886	0.033	0.03	0	46.4	45.6	71	138	135	0	30	29
2015	7	21	19	6	52	0.246	0.01	0.886	0.039	0.036	0	45.6	43.4	71.8	137	130	0	31	29
2015	7	21	19	16	52	0.203	0.046	0.886	0.043	0.039	0	44.3	43.9	73.5	134	130	0	31	28
2015	7	21	19	26	52	0.213	-0.085	0.886	0.039	0.036	0	49.5	47.7	67.1	145	140	0	30	29
2015	7	21	19	36	52	0.24	-0.043	0.886	0.033	0.03	0	51.6	49	65.4	150	143	0	30	29
2015	7	21	19	46	52	0.203	-0.052	0.886	0.039	0.039	0	50.7	48.2	67.5	147	141	0	29	29
2015	7	21	19	56	52	0.266	-0.007	0.883	0.049	0.046	0	50.7	48.6	64.9	148	142	0	30	29
2015	7	21	20	6	52	0.21	-0.013	0.886	0.039	0.036	0	54.6	52.5	62.8	157	151	0	30	29
2015	7	21	20	16	52	0.187	-0.02	0.886	0.039	0.036	0	51.2	49.5	66.7	149	144	0	30	29
2015	7	21	20	26	52	0.236	0	0.886	0.033	0.03	0	49.5	47.3	68.4	145	139	0	30	29
2015	7	21	20	36	52	0.151	-0.03	0.886	0.046	0.043	0	46.9	45.6	69.2	139	135	0	30	29
2015	7	21	20	46	52	0.226	0.095	0.883	0.039	0.036	0	50.3	49	64.9	147	143	0	30	29
2015	7	21	20	56	52	0.22	0.052	0.886	0.033	0.03	0	50.7	48.6	67.1	148	142	0	30	29
2015	7	21	21	6	52	0.21	0.026	0.886	0.039	0.036	0	49.5	47.3	68.8	145	139	0	30	29
2015	7	21	21	16	52	0.174	0.03	0.886	0.033	0.03	0	48.6	47.7	68.8	144	140	0	31	29
2015	7	21	21	26	52	0.253	0.023	0.886	0.036	0.033	0	49	46.9	69.2	144	138	0	30	29
2015	7	21	21	36	52	0.249	0.082	0.886	0.046	0.043	0	48.2	46.4	70.1	142	137	0	30	29
2015	7	21	21	46	52	0.262	0.049	0.886	0.036	0.033	0	47.3	46	71	140	136	0	30	29
2015	7	21	21	56	52	0.184	-0.039	0.886	0.039	0.036	0	47.3	46	70.1	140	136	0	30	29
2015	7	21	22	6	52	0.167	-0.01	0.886	0.039	0.036	0	46.9	44.7	71	140	134	0	31	30
2015	7	21	22	16	52	0.19	0.016	0.886	0.033	0.03	0	45.6	44.7	71.4	137	133	0	31	29
2015	7	21	22	26	52	0.213	0	0.886	0.036	0.033	0	46.4	43.9	72.2	138	131	0	30	29
2015	7	21	22	36	52	0.187	0	0.886	0.043	0.039	0	46	44.3	71.4	137	132	0	30	29
2015	7	21	22	46	52	0.197	-0.007	0.886	0.033	0.03	0	45.6	43.9	72.2	136	131	0	30	29
2015	7	21	22	56	52	0.141	-0.03	0.886	0.039	0.036	0	46	44.7	71.4	137	133	0	30	29
2015	7	21	23	6	52	0.112	-0.052	0.886	0.039	0.039	0	46.9	45.6	71	139	135	0	30	29
2015	7	21	23	16	52	0.161	-0.003	0.889	0.036	0.033	0	46.4	45.2	71.8	138	134	0	30	29
2015	7	21	23	26	52	0.2	-0.082	0.886	0.036	0.033	0	47.7	45.6	71.4	141	135	0	30	29
2015	7	21	23	36	52	0.207	0.075	0.889	0.039	0.036	0	45.6	44.3	73.1	136	132	0	30	29
2015	7	21	23	46	52	0.187	0.007	0.886	0.039	0.036	0	45.2	43.4	72.7	135	130	0	30	29
2015	7	21	23	56	52	0.197	-0.013	0.886	0.039	0.036	0	45.2	43.9	73.5	134	131	0	29	29
2015	7	22	0	6	52	0.171	0.013	0.889	0.033	0.033	0	45.2	44.3	72.7	135	132	0	30	29
2015	7	22	0	16	52	0.141	-0.03	0.886	0.039	0.036	0	44.3	43.4	74	134	131	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	22	0	26	52	0.197	0.046	0.886	0.039	0.036	0	44.7	43.4	73.1	134	130	0	30	29
2015	7	22	0	36	52	0.223	0	0.886	0.039	0.039	0	45.2	43.9	72.7	135	131	0	30	29
2015	7	22	0	46	52	0.203	-0.026	0.886	0.036	0.033	0	44.7	43.4	73.5	135	131	0	31	30
2015	7	22	0	56	52	0.21	0.033	0.886	0.036	0.033	0	45.2	43	72.7	135	129	0	30	29
2015	7	22	1	6	52	0.194	-0.033	0.889	0.033	0.03	0	45.6	43.9	73.1	136	132	0	30	30
2015	7	22	1	16	52	0.19	0.023	0.889	0.033	0.03	0	44.3	42.6	73.1	134	129	0	31	30
2015	7	22	1	26	52	0.197	0	0.886	0.039	0.036	0	44.7	43	73.5	134	130	0	30	30
2015	7	22	1	36	52	0.2	0.02	0.886	0.036	0.033	0	45.6	43.4	73.1	137	131	0	31	30
2015	7	22	1	46	52	0.2	0.01	0.886	0.036	0.033	0	45.2	43.9	74	135	132	0	30	30
2015	7	22	1	56	52	0.177	-0.039	0.886	0.039	0.036	0	44.7	43.9	72.7	134	131	0	30	29
2015	7	22	2	6	52	0.167	-0.033	0.886	0.036	0.033	0	43.9	43.4	74	132	130	0	30	29
2015	7	22	2	16	52	0.213	0.016	0.886	0.043	0.039	0	45.2	43.4	74	135	130	0	30	29
2015	7	22	2	26	52	0.184	-0.026	0.886	0.036	0.033	0	44.7	43	73.5	135	130	0	31	30
2015	7	22	2	36	52	0.174	0.062	0.886	0.033	0.03	0	44.7	43.9	73.1	135	131	0	31	29
2015	7	22	2	46	52	0.148	-0.039	0.886	0.039	0.036	0	45.6	43.4	73.1	136	130	0	30	29
2015	7	22	2	56	52	0.108	-0.01	0.889	0.039	0.036	0	44.7	42.6	74.4	134	128	0	30	29
2015	7	22	3	6	52	0.102	0.007	0.889	0.036	0.033	0	44.3	42.6	74	133	129	0	30	30
2015	7	22	3	16	52	0.164	0	0.889	0.033	0.03	0	44.3	43.9	74	134	131	0	31	29
2015	7	22	3	26	52	0.19	0.013	0.886	0.036	0.033	0	45.6	44.3	73.1	136	133	0	30	30
2015	7	22	3	36	52	0.217	0.036	0.889	0.033	0.03	0	44.7	43	73.5	134	130	0	30	30
2015	7	22	3	46	52	0.151	-0.046	0.889	0.036	0.033	0	44.3	42.6	74	134	129	0	31	30
2015	7	22	3	56	52	0.161	-0.033	0.889	0.043	0.043	0	46.4	44.7	73.5	138	134	0	30	30
2015	7	22	4	6	52	0.203	0.026	0.889	0.036	0.033	0	46	44.3	73.5	137	133	0	30	30
2015	7	22	4	16	52	0.22	-0.056	0.889	0.036	0.033	0	44.3	43.9	74	134	131	0	31	29
2015	7	22	4	26	52	0.184	0.046	0.889	0.036	0.033	0	45.6	43.9	74.4	136	131	0	30	29
2015	7	22	4	36	52	0.22	-0.023	0.889	0.039	0.036	0	45.2	43.4	74	136	131	0	31	30
2015	7	22	4	46	52	0.207	-0.069	0.889	0.039	0.036	0	44.7	43.9	74.8	135	131	0	31	29
2015	7	22	4	56	52	0.112	0	0.889	0.036	0.033	0	44.7	44.7	73.5	135	133	0	31	29
2015	7	22	5	6	52	0.184	-0.007	0.889	0.036	0.033	0	45.6	43.9	74	136	132	0	30	30
2015	7	22	5	16	52	0.223	0.013	0.889	0.036	0.033	0	46	43.9	74	137	132	0	30	30
2015	7	22	5	26	52	0.187	0.01	0.889	0.036	0.033	0	45.6	43.9	73.5	136	132	0	30	30
2015	7	22	5	36	52	0.256	-0.023	0.889	0.036	0.033	0	46.9	44.7	73.1	140	134	0	31	30
2015	7	22	5	46	52	0.171	-0.02	0.889	0.033	0.03	0	46.4	45.2	73.1	138	134	0	30	29
2015	7	22	5	56	52	0.2	-0.023	0.889	0.039	0.036	0	47.7	45.6	72.2	141	136	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	22	6	6	52	0.19	0.007	0.889	0.039	0.039	0	46.9	45.2	73.1	139	135	0	30	30
2015	7	22	6	16	52	0.217	-0.007	0.889	0.039	0.039	0	46.9	44.7	73.5	139	134	0	30	30
2015	7	22	6	26	52	0.174	0.013	0.889	0.039	0.036	0	46.9	45.2	73.5	139	135	0	30	30
2015	7	22	6	36	52	0.151	-0.095	0.892	0.039	0.036	0	46	44.3	74.8	137	132	0	30	29
2015	7	22	6	46	52	0.24	0.013	0.889	0.049	0.046	0	46.9	45.2	73.5	139	134	0	30	29
2015	7	22	6	56	52	0.171	-0.026	0.889	0.036	0.033	0	47.3	46	73.1	141	136	0	31	29
2015	7	22	7	6	52	0.187	-0.082	0.892	0.039	0.039	0	46	44.3	74.4	137	133	0	30	30
2015	7	22	7	16	52	0.167	0.023	0.892	0.043	0.039	0	46.4	44.7	74.4	138	134	0	30	30
2015	7	22	7	26	52	0.154	0.016	0.889	0.033	0.03	0	45.6	43.9	74.4	136	132	0	30	30
2015	7	22	7	36	52	0.24	0.023	0.892	0.033	0.03	0	43.9	43	76.5	132	130	0	30	30
2015	7	22	7	46	52	0.266	0.01	0.892	0.036	0.033	0	46	45.2	74.8	138	134	0	31	29
2015	7	22	7	56	52	0.213	-0.046	0.892	0.036	0.033	0	45.2	44.3	74.8	136	133	0	31	30
2015	7	22	8	6	52	0.22	-0.062	0.892	0.039	0.036	0	46.4	45.2	74.4	139	134	0	31	29
2015	7	22	8	16	52	0.18	-0.02	0.892	0.033	0.03	0	46.9	45.2	75.3	139	135	0	30	30
2015	7	22	8	26	52	0.164	0.095	0.892	0.033	0.03	0	47.3	46	74.4	141	136	0	31	29
2015	7	22	8	36	52	0.24	0.03	0.892	0.036	0.033	0	46	45.2	75.7	137	135	0	30	30
2015	7	22	8	46	52	0.203	-0.026	0.892	0.039	0.036	0	45.6	45.2	75.7	136	135	0	30	30
2015	7	22	8	56	52	0.177	-0.039	0.892	0.033	0.03	0	46	46.4	76.5	137	138	0	30	30
2015	7	22	9	6	52	0.171	-0.01	0.892	0.033	0.03	0	46.9	46.9	74	139	139	0	30	30
2015	7	22	9	16	52	0.217	-0.01	0.892	0.039	0.036	0	46.4	46.9	75.7	138	138	0	30	29
2015	7	22	9	26	52	0.2	-0.003	0.892	0.039	0.036	0	47.3	46	74.4	140	137	0	30	30
2015	7	22	9	36	52	0.21	0.026	0.892	0.036	0.033	0	49.5	47.7	72.7	146	141	0	31	30
2015	7	22	9	46	52	0.125	0.03	0.892	0.039	0.036	0	46.4	46.4	74.4	139	138	0	31	30
2015	7	22	9	56	52	0.262	-0.069	0.892	0.03	0.03	0	47.7	46.9	75.3	141	139	0	30	30
2015	7	22	10	6	52	0.24	0.016	0.892	0.033	0.03	0	47.7	47.7	74	142	141	0	31	30
2015	7	22	10	16	52	0.194	-0.003	0.892	0.033	0.03	0	47.7	48.6	74.4	142	142	0	31	29
2015	7	22	10	26	52	0.21	0.052	0.892	0.033	0.03	0	47.3	49	72.7	141	144	0	31	30
2015	7	22	10	36	52	0.207	-0.016	0.892	0.033	0.03	0	49.9	50.3	71.4	146	146	0	30	29
2015	7	22	10	46	52	0.223	-0.02	0.892	0.033	0.03	0	49.9	50.3	73.1	146	146	0	30	29
2015	7	22	10	56	52	0.108	0.016	0.892	0.036	0.033	0	49.9	51.2	70.5	147	148	0	31	29
2015	7	22	11	6	52	0.223	0.003	0.892	0.033	0.03	0	50.7	52.5	70.1	148	151	0	30	29
2015	7	22	11	16	52	0.187	0.03	0.892	0.033	0.03	0	51.2	52.5	70.1	150	151	0	31	29
2015	7	22	11	26	52	0.164	0.023	0.889	0.039	0.039	0	51.6	52	69.2	150	150	0	30	29
2015	7	22	11	36	52	0.203	0.056	0.889	0.036	0.033	0	51.6	53.3	69.7	151	153	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	22	11	46	52	0.207	-0.013	0.889	0.033	0.03	0	51.6	52.5	67.9	151	151	0	31	29
2015	7	22	11	56	52	0.249	0.072	0.889	0.033	0.03	0	51.6	52.9	68.8	151	153	0	31	30
2015	7	22	12	6	52	0.184	0.016	0.889	0.033	0.03	0	53.8	53.8	67.5	155	155	0	30	30
2015	7	22	12	16	52	0.253	0.085	0.889	0.033	0.03	0	53.3	53.8	67.5	154	155	0	30	30
2015	7	22	12	26	52	0.253	0.069	0.889	0.039	0.036	0	53.3	52.5	67.9	154	152	0	30	30
2015	7	22	12	36	52	0.144	0.128	0.886	0.039	0.036	0	56.3	55.5	63.2	161	159	0	30	30
2015	7	22	12	46	52	0.154	0.105	0.889	0.033	0.03	0	55.5	55.5	64.5	159	158	0	30	29
2015	7	22	12	56	52	0.19	0.033	0.886	0.036	0.033	0	54.2	54.6	65.4	156	156	0	30	29
2015	7	22	13	6	52	0.187	0.135	0.889	0.036	0.033	0	51.6	52.5	66.7	150	151	0	30	29
2015	7	22	13	16	52	0.223	0.026	0.886	0.033	0.03	0	51.6	51.6	66.7	151	149	0	31	29
2015	7	22	13	26	52	0.207	0.121	0.889	0.033	0.03	0	55.5	54.6	65.4	159	156	0	30	29
2015	7	22	13	36	52	0.213	0.125	0.886	0.036	0.033	0	55.5	55.5	65.8	159	158	0	30	29
2015	7	22	13	46	52	0.23	0.003	0.886	0.036	0.033	0	55.5	55.5	64.1	158	158	0	29	29
2015	7	22	13	56	52	0.246	0.049	0.886	0.033	0.03	0	55.9	55.5	63.6	160	158	0	30	29
2015	7	22	14	6	52	0.203	0.046	0.886	0.033	0.03	0	54.2	55	64.9	156	157	0	30	29
2015	7	22	14	16	52	0.249	0.151	0.886	0.039	0.036	0	55	54.6	64.1	158	156	0	30	29
2015	7	22	14	26	52	0.177	0.066	0.886	0.036	0.033	0	54.6	55	64.9	157	156	0	30	28
2015	7	22	14	36	52	0.184	0.02	0.886	0.033	0.03	0	52.9	53.3	66.2	153	153	0	30	29
2015	7	22	14	46	52	0.253	0.092	0.886	0.036	0.033	0	49	49.5	68.8	144	144	0	30	29
2015	7	22	14	56	52	0.19	0.007	0.886	0.039	0.036	0	50.3	49	69.2	147	143	0	30	29
2015	7	22	15	6	52	0.2	0.036	0.886	0.033	0.03	0	51.6	51.2	66.2	150	148	0	30	29
2015	7	22	15	16	52	0.19	0.151	0.886	0.033	0.03	0	51.2	50.7	67.9	149	147	0	30	29
2015	7	22	15	26	52	0.226	0.013	0.886	0.036	0.033	0	49.5	49	69.2	145	143	0	30	29
2015	7	22	15	36	52	0.171	0	0.886	0.036	0.033	0	50.7	49.9	67.5	148	145	0	30	29
2015	7	22	15	46	52	0.243	0.016	0.886	0.036	0.033	0	48.6	48.2	69.7	144	142	0	31	30
2015	7	22	15	56	52	0.2	-0.003	0.886	0.036	0.033	0	48.2	46.4	68.8	141	137	0	29	29
2015	7	22	16	6	52	0.272	0.01	0.886	0.036	0.033	0	49	47.7	67.9	144	140	0	30	29
2015	7	22	16	16	52	0.164	0.131	0.886	0.039	0.039	0	49.5	48.2	67.9	145	141	0	30	29
2015	7	22	16	26	52	0.22	0.092	0.886	0.039	0.036	0	49	47.3	68.4	144	139	0	30	29
2015	7	22	16	36	52	0.246	0.066	0.886	0.033	0.03	0	49.5	47.3	67.9	145	139	0	30	29
2015	7	22	16	46	52	0.24	0.098	0.886	0.036	0.033	0	49	46	69.7	143	136	0	29	29
2015	7	22	16	56	52	0.151	0.007	0.886	0.039	0.036	0	46.9	44.7	69.7	140	133	0	31	29
2015	7	22	17	6	52	0.144	-0.02	0.886	0.033	0.03	0	46.9	44.3	71	139	132	0	30	29
2015	7	22	17	16	52	0.233	-0.003	0.886	0.033	0.03	0	46	44.3	71.8	137	132	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	22	17	26	52	0.207	0.003	0.886	0.039	0.036	0	45.6	43	72.7	135	130	0	29	30
2015	7	22	17	36	52	0.223	-0.01	0.886	0.039	0.036	0	45.2	43.4	71.8	135	130	0	30	29
2015	7	22	17	46	52	0.207	0.01	0.886	0.039	0.036	0	45.2	43.4	72.2	135	130	0	30	29
2015	7	22	17	56	52	0.207	0.056	0.886	0.039	0.039	0	45.2	44.3	72.2	136	132	0	31	29
2015	7	22	18	6	52	0.148	0.023	0.886	0.039	0.039	0	46.9	45.2	70.5	139	134	0	30	29
2015	7	22	18	16	52	0.243	0.046	0.886	0.036	0.033	0	47.7	45.6	69.7	141	135	0	30	29
2015	7	22	18	26	52	0.207	0	0.886	0.046	0.043	0	48.2	46	70.5	142	136	0	30	29
2015	7	22	18	36	52	0.23	-0.02	0.886	0.039	0.036	0	49.5	47.3	68.8	145	139	0	30	29
2015	7	22	18	46	52	0.2	0.049	0.886	0.039	0.036	0	52.5	49.9	65.8	152	145	0	30	29
2015	7	22	18	56	52	0.171	-0.023	0.886	0.039	0.036	0	52.9	50.3	64.9	153	147	0	30	30
2015	7	22	19	6	52	0.19	0	0.886	0.043	0.039	0	55.5	53.3	61.9	159	153	0	30	29
2015	7	22	19	16	52	0.21	0.049	0.886	0.036	0.033	0	53.3	50.7	64.5	154	148	0	30	30
2015	7	22	19	26	52	0.22	-0.069	0.886	0.039	0.036	0	54.6	52.9	62.8	158	152	0	31	29
2015	7	22	19	36	52	0.23	-0.02	0.886	0.036	0.033	0	55	52.5	62.8	158	151	0	30	29
2015	7	22	19	46	52	0.141	0.007	0.886	0.039	0.039	0	55.5	53.8	61.5	159	153	0	30	28
2015	7	22	19	56	52	0.207	0.03	0.886	0.052	0.049	0	55	52.5	63.2	157	151	0	29	29
2015	7	22	20	6	52	0.174	0.046	0.886	0.043	0.039	0	56.3	54.2	61.5	161	155	0	30	29
2015	7	22	20	16	52	0.243	0.007	0.886	0.043	0.039	0	55.9	53.3	61.1	161	154	0	31	30
2015	7	22	20	26	52	0.135	-0.02	0.886	0.043	0.039	0	51.6	49.5	66.7	150	144	0	30	29
2015	7	22	20	36	52	0.141	-0.02	0.886	0.039	0.036	0	53.3	51.2	64.5	154	148	0	30	29
2015	7	22	20	46	52	0.23	-0.03	0.886	0.046	0.043	0	52.5	49.9	65.4	152	145	0	30	29
2015	7	22	20	56	52	0.18	-0.02	0.886	0.039	0.039	0	52.5	50.3	64.9	152	146	0	30	29
2015	7	22	21	6	52	0.197	0.039	0.886	0.049	0.046	0	55	52.9	62.4	159	153	0	31	30
2015	7	22	21	16	52	0.213	-0.046	0.886	0.039	0.039	0	53.3	50.7	65.4	154	148	0	30	30
2015	7	22	21	26	52	0.144	0.026	0.886	0.033	0.03	0	53.3	51.6	64.5	154	149	0	30	29
2015	7	22	21	36	52	0.167	-0.02	0.886	0.039	0.039	0	52	50.3	65.8	151	146	0	30	29
2015	7	22	21	46	52	0.2	-0.003	0.889	0.043	0.039	0	52	49.5	66.2	151	145	0	30	30
2015	7	22	21	56	52	0.262	-0.036	0.886	0.039	0.039	0	53.8	52	64.1	156	150	0	31	29
2015	7	22	22	6	52	0.157	-0.03	0.886	0.039	0.036	0	54.6	52.9	63.2	157	152	0	30	29
2015	7	22	22	16	52	0.233	0.049	0.886	0.033	0.03	0	54.6	52.9	63.6	157	152	0	30	29
2015	7	22	22	26	52	0.259	-0.056	0.889	0.046	0.043	0	51.6	49	66.2	150	144	0	30	30
2015	7	22	22	36	52	0.2	0	0.889	0.036	0.033	0	52.9	50.7	65.4	153	147	0	30	29
2015	7	22	22	46	52	0.223	0.052	0.889	0.043	0.039	0	53.8	52	64.1	156	151	0	31	30
2015	7	22	22	56	52	0.203	-0.03	0.889	0.043	0.039	0	54.2	52	64.1	156	151	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	22	23	6	52	0.187	-0.039	0.889	0.039	0.039	0	50.3	47.7	68.8	147	140	0	30	29
2015	7	22	23	16	52	0.157	-0.115	0.889	0.036	0.033	0	52.5	50.3	65.8	152	147	0	30	30
2015	7	22	23	26	52	0.197	0.013	0.889	0.036	0.033	0	49.5	47.3	69.7	145	139	0	30	29
2015	7	22	23	36	52	0.174	-0.013	0.889	0.039	0.039	0	51.2	48.6	67.9	149	142	0	30	29
2015	7	22	23	46	52	0.217	-0.003	0.889	0.039	0.039	0	49	47.3	70.5	144	140	0	30	30
2015	7	22	23	56	52	0.2	-0.066	0.889	0.039	0.039	0	49	46	70.1	144	137	0	30	30
2015	7	23	0	6	52	0.187	-0.026	0.889	0.039	0.039	0	47.3	44.7	72.7	140	133	0	30	29
2015	7	23	0	16	52	0.154	0.026	0.889	0.043	0.039	0	49	47.3	70.5	144	140	0	30	30
2015	7	23	0	26	52	0.217	-0.01	0.889	0.039	0.036	0	45.6	44.3	73.1	136	132	0	30	29
2015	7	23	0	36	52	0.161	-0.016	0.889	0.039	0.039	0	46	44.3	73.1	137	132	0	30	29
2015	7	23	0	46	52	0.19	-0.046	0.889	0.039	0.039	0	46	44.3	72.7	137	132	0	30	29
2015	7	23	0	56	52	0.121	-0.059	0.889	0.036	0.033	0	45.6	43.9	73.1	137	132	0	31	30
2015	7	23	1	6	52	0.236	-0.036	0.889	0.039	0.036	0	46	44.7	72.7	137	133	0	30	29
2015	7	23	1	16	52	0.187	-0.056	0.889	0.039	0.036	0	46	43.9	73.5	137	131	0	30	29
2015	7	23	1	26	52	0.148	-0.049	0.889	0.039	0.039	0	45.6	43.4	73.5	137	131	0	31	30
2015	7	23	1	36	52	0.328	-0.02	0.889	0.036	0.033	0	46	44.3	72.2	138	133	0	31	30
2015	7	23	1	46	52	0.269	-0.007	0.889	0.039	0.036	0	48.2	46	71.8	142	136	0	30	29
2015	7	23	1	56	52	0.121	-0.082	0.889	0.036	0.033	0	44.7	43.4	73.5	135	131	0	31	30
2015	7	23	2	6	52	0.187	0.026	0.889	0.036	0.033	0	44.7	43.4	74.8	134	130	0	30	29
2015	7	23	2	16	52	0.213	-0.02	0.889	0.039	0.036	0	48.6	45.6	72.2	143	135	0	30	29
2015	7	23	2	26	52	0.256	0	0.889	0.033	0.03	0	44.3	43.4	74.4	133	130	0	30	29
2015	7	23	2	36	52	0.203	-0.043	0.889	0.039	0.039	0	45.2	43.4	74	135	130	0	30	29
2015	7	23	2	46	52	0.148	0	0.889	0.039	0.036	0	44.3	42.6	75.3	133	128	0	30	29
2015	7	23	2	56	52	0.144	0.016	0.889	0.039	0.039	0	43.9	43.4	75.3	132	130	0	30	29
2015	7	23	3	6	52	0.151	-0.03	0.889	0.036	0.033	0	45.6	44.3	74	137	132	0	31	29
2015	7	23	3	16	52	0.236	-0.03	0.889	0.043	0.039	0	45.2	43.9	74	135	131	0	30	29
2015	7	23	3	26	52	0.22	-0.016	0.889	0.039	0.036	0	44.3	43.9	74.8	133	131	0	30	29
2015	7	23	3	36	52	0.194	0.066	0.889	0.039	0.036	0	47.3	45.6	72.7	140	135	0	30	29
2015	7	23	3	46	52	0.19	-0.036	0.889	0.036	0.033	0	45.6	43.9	73.5	136	132	0	30	30
2015	7	23	3	56	52	0.171	-0.043	0.892	0.033	0.03	0	45.6	44.7	74	137	134	0	31	30
2015	7	23	4	6	52	0.22	-0.02	0.889	0.036	0.033	0	46.9	43.9	74	139	132	0	30	30
2015	7	23	4	16	52	0.223	-0.02	0.889	0.039	0.036	0	44.7	43.9	74.4	135	131	0	31	29
2015	7	23	4	26	52	0.125	0	0.892	0.036	0.033	0	45.6	44.3	74.8	136	132	0	30	29
2015	7	23	4	36	52	0.105	0	0.889	0.036	0.033	0	45.2	43.4	75.3	135	130	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	23	4	46	52	0.233	0.056	0.892	0.036	0.033	0	45.6	44.3	74.4	136	132	0	30	29
2015	7	23	4	56	52	0.223	0.013	0.889	0.039	0.036	0	45.6	43.4	74	136	131	0	30	30
2015	7	23	5	6	52	0.141	0	0.892	0.039	0.036	0	45.6	44.3	74.4	137	133	0	31	30
2015	7	23	5	16	52	0.197	0.052	0.889	0.033	0.03	0	44.7	43.9	74.4	135	132	0	31	30
2015	7	23	5	26	52	0.223	-0.02	0.892	0.039	0.036	0	44.3	43	74.4	134	130	0	31	30
2015	7	23	5	36	52	0.161	0.003	0.892	0.039	0.039	0	45.2	43.9	75.3	136	131	0	31	29
2015	7	23	5	46	52	0.177	-0.072	0.892	0.033	0.03	0	46	45.2	74	138	135	0	31	30
2015	7	23	5	56	52	0.22	-0.016	0.892	0.036	0.033	0	45.2	42.6	75.7	135	129	0	30	30
2015	7	23	6	6	52	0.154	-0.033	0.892	0.039	0.036	0	44.7	43	74.8	134	130	0	30	30
2015	7	23	6	16	52	0.154	-0.02	0.892	0.036	0.033	0	45.2	43.9	74	136	132	0	31	30
2015	7	23	6	26	52	0.223	-0.095	0.892	0.039	0.036	0	44.7	43.4	74.8	135	131	0	31	30
2015	7	23	6	36	52	0.197	-0.046	0.892	0.036	0.033	0	45.2	43.4	75.7	136	131	0	31	30
2015	7	23	6	46	52	0.184	-0.102	0.892	0.036	0.033	0	44.7	43.4	74.8	134	130	0	30	29
2015	7	23	6	56	52	0.2	0.003	0.892	0.039	0.039	0	45.6	45.2	74	137	134	0	31	29
2015	7	23	7	6	52	0.217	-0.066	0.892	0.039	0.036	0	43.9	43.4	76.1	132	131	0	30	30
2015	7	23	7	16	52	0.213	-0.023	0.892	0.036	0.033	0	45.6	44.3	74	136	133	0	30	30
2015	7	23	7	26	52	0.118	0.039	0.889	0.039	0.039	0	47.7	45.2	73.1	141	135	0	30	30
2015	7	23	7	36	52	0.184	-0.062	0.892	0.036	0.033	0	44.7	43.9	75.3	135	132	0	31	30
2015	7	23	7	46	52	0.174	-0.052	0.892	0.039	0.039	0	45.2	43.9	74.8	136	131	0	31	29
2015	7	23	7	56	52	0.128	-0.036	0.892	0.039	0.039	0	46.4	45.2	74	138	135	0	30	30
2015	7	23	8	6	52	0.174	0.03	0.892	0.036	0.033	0	44.3	43.9	75.7	134	132	0	31	30
2015	7	23	8	16	52	0.236	0.007	0.892	0.036	0.033	0	44.3	43	76.1	134	130	0	31	30
2015	7	23	8	26	52	0.184	-0.062	0.892	0.039	0.039	0	44.7	44.7	75.3	135	134	0	31	30
2015	7	23	8	36	52	0.262	-0.007	0.892	0.039	0.039	0	44.7	44.3	75.7	135	133	0	31	30
2015	7	23	8	46	52	0.157	-0.056	0.892	0.039	0.036	0	44.3	44.7	75.7	134	133	0	31	29
2015	7	23	8	56	52	0.131	-0.026	0.892	0.039	0.036	0	47.3	46.4	73.1	141	138	0	31	30
2015	7	23	9	6	52	0.213	0	0.892	0.036	0.033	0	48.2	47.3	72.2	143	139	0	31	29
2015	7	23	9	16	52	0.121	-0.01	0.892	0.036	0.033	0	48.6	47.7	72.2	143	141	0	30	30
2015	7	23	9	26	52	0.197	0.052	0.892	0.039	0.036	0	50.3	48.6	71.4	148	143	0	31	30
2015	7	23	9	36	52	0.151	-0.03	0.892	0.033	0.03	0	52	51.6	68.8	152	149	0	31	29
2015	7	23	9	46	52	0.217	-0.02	0.892	0.033	0.03	0	50.3	47.7	71.4	147	141	0	30	30
2015	7	23	9	56	52	0.18	0.046	0.892	0.033	0.03	0	46.9	46	73.5	140	137	0	31	30
2015	7	23	10	6	52	0.249	-0.043	0.892	0.039	0.036	0	49.5	47.3	71.4	146	140	0	31	30
2015	7	23	10	16	52	0.233	0.026	0.892	0.039	0.036	0	48.6	47.3	72.7	144	140	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	23	10	26	52	0.253	0.036	0.892	0.039	0.036	0	48.6	46.9	71.4	144	139	0	31	30
2015	7	23	10	36	52	0.187	0.01	0.892	0.036	0.033	0	47.7	46.4	73.1	141	137	0	30	29
2015	7	23	10	46	52	0.138	-0.036	0.889	0.039	0.036	0	48.6	47.7	71	143	141	0	30	30
2015	7	23	10	56	52	0.184	-0.039	0.892	0.039	0.036	0	48.2	46.9	72.2	143	138	0	31	29
2015	7	23	11	6	52	0.167	0.033	0.889	0.036	0.033	0	46.4	46.4	73.1	139	137	0	31	29
2015	7	23	11	16	52	0.223	-0.02	0.889	0.043	0.043	0	49.5	48.2	70.5	145	142	0	30	30
2015	7	23	11	26	52	0.23	-0.013	0.889	0.039	0.039	0	48.6	48.6	71	143	142	0	30	29
2015	7	23	11	36	52	0.243	-0.007	0.889	0.039	0.036	0	46.9	46.9	71.8	139	139	0	30	30
2015	7	23	11	46	52	0.151	-0.03	0.889	0.03	0.03	0	48.2	47.3	72.2	142	139	0	30	29
2015	7	23	11	56	52	0.177	0.01	0.889	0.033	0.03	0	46.9	46.9	71.8	139	138	0	30	29
2015	7	23	12	6	52	0.194	0.033	0.886	0.033	0.03	0	47.7	47.3	71.8	141	140	0	30	30
2015	7	23	12	16	52	0.213	-0.036	0.886	0.036	0.033	0	50.3	48.6	69.2	147	143	0	30	30
2015	7	23	12	26	52	0.253	-0.062	0.886	0.036	0.033	0	51.6	50.3	67.5	150	147	0	30	30
2015	7	23	12	36	52	0.187	0.02	0.886	0.033	0.03	0	50.3	49.5	69.7	148	144	0	31	29
2015	7	23	12	46	52	0.223	-0.03	0.886	0.043	0.039	0	50.7	50.7	67.1	149	147	0	31	29
2015	7	23	12	56	52	0.246	0	0.886	0.039	0.036	0	50.7	49.9	67.1	148	146	0	30	30
2015	7	23	13	6	52	0.171	0.089	0.886	0.039	0.036	0	52	51.2	67.9	151	148	0	30	29
2015	7	23	13	16	52	0.177	-0.026	0.886	0.039	0.036	0	50.7	49.9	67.9	149	146	0	31	30
2015	7	23	13	26	52	0.128	-0.016	0.886	0.036	0.033	0	51.2	50.7	67.9	149	147	0	30	29
2015	7	23	13	36	52	0.197	-0.062	0.883	0.036	0.033	0	51.6	50.7	67.1	150	147	0	30	29
2015	7	23	13	46	52	0.197	0	0.883	0.033	0.03	0	51.6	51.2	66.7	150	148	0	30	29
2015	7	23	13	56	52	0.315	0.062	0.883	0.039	0.039	0	52	51.6	66.2	151	149	0	30	29
2015	7	23	14	6	52	0.223	0.01	0.883	0.036	0.033	0	52.9	52.5	64.9	153	151	0	30	29
2015	7	23	14	16	52	0.069	0.016	0.883	0.039	0.036	0	52	51.2	65.8	151	149	0	30	30
2015	7	23	14	26	52	0.23	0.003	0.883	0.036	0.033	0	49	47.7	68.8	144	140	0	30	29
2015	7	23	14	36	52	0.19	0.039	0.879	0.033	0.03	0	51.2	50.3	66.7	149	146	0	30	29
2015	7	23	14	46	52	0.157	0.013	0.879	0.039	0.039	0	50.3	49	68.8	147	143	0	30	29
2015	7	23	14	56	52	0.177	0.056	0.876	0.033	0.03	0	50.7	49.9	67.9	148	145	0	30	29
2015	7	23	15	6	52	0.19	0.049	0.876	0.033	0.03	0	48.2	48.2	68.8	143	141	0	31	29
2015	7	23	15	16	52	0.164	0	0.876	0.039	0.036	0	46.4	45.6	69.7	138	136	0	30	30
2015	7	23	15	26	52	0.18	0.092	0.876	0.033	0.03	0	48.6	47.7	69.2	144	140	0	31	29
2015	7	23	15	36	52	0.164	0.016	0.873	0.036	0.033	0	49	47.7	68.8	144	140	0	30	29
2015	7	23	15	46	52	0.125	0.046	0.873	0.039	0.036	0	48.6	46.4	70.1	143	137	0	30	29
2015	7	23	15	56	52	0.18	0.023	0.873	0.036	0.033	0	47.7	46.9	69.7	141	139	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	23	16	6	52	0.144	0.02	0.873	0.033	0.03	0	49.5	49	68.8	145	143	0	30	29
2015	7	23	16	16	52	0.154	0.059	0.873	0.036	0.033	0	50.3	48.6	68.8	147	143	0	30	30
2015	7	23	16	26	52	0.135	0.007	0.873	0.036	0.033	0	49.5	48.2	67.5	145	141	0	30	29
2015	7	23	16	36	52	0.23	0.026	0.873	0.036	0.033	0	49	47.7	68.4	144	140	0	30	29
2015	7	23	16	46	52	0.184	0.033	0.869	0.039	0.036	0	50.7	48.6	69.2	148	142	0	30	29
2015	7	23	16	56	52	0.154	-0.03	0.869	0.039	0.039	0	49.5	49	68.8	145	143	0	30	29
2015	7	23	17	6	52	0.171	0.023	0.869	0.033	0.03	0	49.9	48.2	68.4	146	141	0	30	29
2015	7	23	17	16	52	0.154	0.016	0.869	0.036	0.033	0	49	47.7	69.7	144	140	0	30	29
2015	7	23	17	26	52	0.22	0.007	0.869	0.036	0.033	0	47.7	46	70.5	141	136	0	30	29
2015	7	23	17	36	52	0.118	0.062	0.869	0.036	0.033	0	47.3	45.2	71.8	140	135	0	30	30
2015	7	23	17	46	52	0.269	0.043	0.869	0.033	0.03	0	46.4	45.6	71.4	138	135	0	30	29
2015	7	23	17	56	52	0.144	0.026	0.869	0.039	0.036	0	45.2	44.3	72.2	135	133	0	30	30
2015	7	23	18	6	52	0.125	0.056	0.869	0.039	0.039	0	46.4	45.6	71.8	138	135	0	30	29
2015	7	23	18	16	52	0.184	0.02	0.869	0.039	0.036	0	45.2	44.3	71.4	135	132	0	30	29
2015	7	23	18	26	52	0.223	0.033	0.866	0.039	0.036	0	49	48.2	68.4	144	141	0	30	29
2015	7	23	18	36	52	0.148	0.036	0.869	0.036	0.033	0	49	47.7	67.5	144	140	0	30	29
2015	7	23	18	46	52	0.253	0	0.869	0.039	0.036	0	47.7	46.9	70.1	142	138	0	31	29
2015	7	23	18	56	52	0.2	0.033	0.869	0.039	0.036	0	47.7	46.4	69.7	141	137	0	30	29
2015	7	23	19	6	52	0.2	0.033	0.869	0.039	0.036	0	47.7	46.4	70.1	141	137	0	30	29
2015	7	23	19	16	52	0.226	0.013	0.869	0.033	0.03	0	47.3	46.4	70.5	140	137	0	30	29
2015	7	23	19	26	52	0.217	-0.01	0.866	0.039	0.036	0	50.7	49	67.1	148	143	0	30	29
2015	7	23	19	36	52	0.19	0.016	0.866	0.049	0.046	0	49.9	48.2	68.4	146	141	0	30	29
2015	7	23	19	46	52	0.269	0.033	0.869	0.039	0.039	0	48.6	46.9	68.8	143	138	0	30	29
2015	7	23	19	56	52	0.194	0	0.866	0.039	0.039	0	51.2	49	67.5	149	143	0	30	29
2015	7	23	20	6	52	0.167	-0.01	0.869	0.039	0.039	0	49.5	47.7	68.8	145	140	0	30	29
2015	7	23	20	16	52	0.177	-0.01	0.866	0.039	0.036	0	49.9	48.6	67.5	146	142	0	30	29
2015	7	23	20	26	52	0.154	-0.01	0.869	0.033	0.03	0	48.6	47.3	68.8	143	139	0	30	29
2015	7	23	20	36	52	0.187	-0.007	0.869	0.043	0.039	0	48.6	46.9	69.7	143	138	0	30	29
2015	7	23	20	46	52	0.135	-0.039	0.866	0.039	0.039	0	49.5	47.7	68.8	145	140	0	30	29
2015	7	23	20	56	52	0.128	0.02	0.869	0.039	0.039	0	48.6	47.3	69.2	143	139	0	30	29
2015	7	23	21	6	52	0.22	-0.039	0.869	0.039	0.039	0	48.6	47.3	68.8	143	139	0	30	29
2015	7	23	21	16	52	0.194	0.026	0.869	0.039	0.036	0	49.5	47.3	68.4	145	139	0	30	29
2015	7	23	21	26	52	0.19	-0.056	0.869	0.036	0.033	0	48.2	46.4	70.1	142	137	0	30	29
2015	7	23	21	36	52	0.131	-0.007	0.866	0.039	0.039	0	47.7	46	71	141	136	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	23	21	46	52	0.157	0.075	0.869	0.039	0.036	0	47.3	45.2	71.4	140	135	0	30	30
2015	7	23	21	56	52	0.203	0.052	0.869	0.036	0.033	0	45.6	45.2	71.8	136	134	0	30	29
2015	7	23	22	6	52	0.184	0.01	0.869	0.039	0.036	0	45.6	44.7	72.2	136	133	0	30	29
2015	7	23	22	16	52	0.197	-0.013	0.866	0.036	0.033	0	45.2	44.3	72.7	135	132	0	30	29
2015	7	23	22	26	52	0.21	0.003	0.869	0.039	0.039	0	46	44.7	72.2	137	134	0	30	30
2015	7	23	22	36	52	0.154	0.089	0.866	0.039	0.036	0	44.7	43.9	72.7	135	131	0	31	29
2015	7	23	22	46	52	0.197	-0.059	0.866	0.039	0.036	0	45.2	43.9	72.7	135	131	0	30	29
2015	7	23	22	56	52	0.131	-0.075	0.866	0.036	0.033	0	44.7	43.9	72.2	134	132	0	30	30
2015	7	23	23	6	52	0.121	-0.033	0.866	0.039	0.036	0	45.2	43.9	72.7	135	131	0	30	29
2015	7	23	23	16	52	0.151	0.016	0.866	0.039	0.039	0	44.7	43.9	72.7	134	131	0	30	29
2015	7	23	23	26	52	0.19	0.023	0.866	0.033	0.03	0	46	43.9	73.1	137	131	0	30	29
2015	7	23	23	36	52	0.138	-0.026	0.866	0.036	0.033	0	45.2	44.7	73.5	135	133	0	30	29
2015	7	23	23	46	52	0.194	0.043	0.866	0.043	0.039	0	46.4	46	71.8	137	135	0	29	28
2015	7	23	23	56	52	0.161	-0.066	0.866	0.036	0.033	0	44.3	43.4	72.7	134	130	0	31	29
2015	7	24	0	6	52	0.112	0.023	0.866	0.039	0.036	0	43.4	43.4	73.1	131	130	0	30	29
2015	7	24	0	16	52	0.177	0	0.866	0.033	0.03	0	44.3	42.6	74	133	129	0	30	30
2015	7	24	0	26	52	0.135	-0.007	0.866	0.039	0.036	0	43.4	42.6	74	131	128	0	30	29
2015	7	24	0	36	52	0.157	-0.039	0.866	0.036	0.033	0	44.3	43	74	133	129	0	30	29
2015	7	24	0	46	52	0.092	-0.049	0.866	0.03	0.026	0	43.9	43	73.5	132	129	0	30	29
2015	7	24	0	56	52	0.085	-0.075	0.866	0.049	0.046	0	44.7	44.7	72.7	134	133	0	30	29
2015	7	24	1	6	52	0.075	-0.072	0.866	0.046	0.046	0	44.7	44.7	71.8	135	134	0	31	30
2015	7	24	1	16	52	0.092	0.043	0.866	0.039	0.039	0	47.3	45.6	71.4	140	136	0	30	30
2015	7	24	1	26	52	0.108	0.039	0.866	0.039	0.039	0	45.2	43.4	73.5	135	130	0	30	29
2015	7	24	1	36	52	0.148	0.016	0.866	0.036	0.033	0	43.9	42.6	74	133	129	0	31	30
2015	7	24	1	46	52	0.23	-0.03	0.866	0.033	0.03	0	43.4	43	73.1	132	130	0	31	30
2015	7	24	1	56	52	0.213	-0.013	0.866	0.033	0.03	0	43.4	43	73.5	131	130	0	30	30
2015	7	24	2	6	52	0.174	-0.046	0.866	0.036	0.033	0	43.4	42.6	74	131	129	0	30	30
2015	7	24	2	16	52	0.112	-0.125	0.866	0.039	0.036	0	43.4	42.6	73.5	131	129	0	30	30
2015	7	24	2	26	52	0.21	-0.082	0.866	0.039	0.039	0	43	42.6	74.4	131	128	0	31	29
2015	7	24	2	36	52	0.19	0	0.866	0.036	0.033	0	43	41.7	74	130	127	0	30	30
2015	7	24	2	46	52	0.23	-0.007	0.866	0.039	0.036	0	43.4	42.6	73.5	131	128	0	30	29
2015	7	24	2	56	52	0.154	-0.059	0.866	0.036	0.033	0	43	42.6	74	131	129	0	31	30
2015	7	24	3	6	52	0.135	-0.046	0.866	0.033	0.03	0	43.4	42.1	74.4	132	128	0	31	30
2015	7	24	3	16	52	0.174	0	0.866	0.039	0.036	0	44.3	43	72.2	133	130	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	24	3	26	52	0.187	-0.062	0.866	0.039	0.039	0	43.4	43.4	72.7	132	130	0	31	29
2015	7	24	3	36	52	0.226	0.056	0.866	0.039	0.039	0	45.6	43.9	72.7	136	132	0	30	30
2015	7	24	3	46	52	0.19	0.056	0.866	0.039	0.036	0	44.3	43.4	73.1	134	131	0	31	30
2015	7	24	3	56	52	0.154	-0.039	0.866	0.036	0.033	0	43.4	44.7	72.2	132	134	0	31	30
2015	7	24	4	6	52	0.171	0.02	0.866	0.039	0.036	0	44.7	43.4	72.7	134	131	0	30	30
2015	7	24	4	16	52	0.167	0.023	0.866	0.033	0.03	0	43.4	43	72.2	132	130	0	31	30
2015	7	24	4	26	52	0.105	-0.023	0.866	0.033	0.03	0	44.3	43.4	72.7	134	130	0	31	29
2015	7	24	4	36	52	0.18	0	0.866	0.036	0.033	0	43.9	43	72.2	132	130	0	30	30
2015	7	24	4	46	52	0.125	-0.023	0.866	0.036	0.033	0	43.4	43.9	72.2	132	131	0	31	29
2015	7	24	4	56	52	0.164	-0.007	0.866	0.036	0.033	0	43.9	43.9	71.4	133	131	0	31	29
2015	7	24	5	6	52	0.105	-0.016	0.869	0.039	0.039	0	44.7	43.4	71	135	131	0	31	30
2015	7	24	5	16	52	0.207	0.023	0.869	0.039	0.036	0	43.9	43	71.8	132	130	0	30	30
2015	7	24	5	26	52	0.121	0.01	0.869	0.033	0.03	0	45.2	43.9	71	135	132	0	30	30
2015	7	24	5	36	52	0.194	-0.075	0.869	0.039	0.036	0	48.6	46.4	67.1	143	138	0	30	30
2015	7	24	5	46	52	0.167	-0.056	0.869	0.036	0.033	0	48.2	46.4	67.9	142	138	0	30	30
2015	7	24	5	56	52	0.203	-0.089	0.873	0.033	0.03	0	46.4	45.2	69.2	138	135	0	30	30
2015	7	24	6	6	52	0.23	-0.056	0.873	0.039	0.039	0	48.2	46.9	67.5	143	139	0	31	30
2015	7	24	6	16	52	0.095	-0.013	0.876	0.043	0.039	0	46.4	45.6	69.2	138	135	0	30	29
2015	7	24	6	26	52	0.151	0.016	0.876	0.036	0.033	0	46.9	45.6	68.8	139	136	0	30	30
2015	7	24	6	36	52	0.203	0.003	0.876	0.036	0.033	0	45.6	44.7	69.2	137	134	0	31	30
2015	7	24	6	46	52	0.164	-0.056	0.876	0.039	0.036	0	46.4	45.6	69.2	139	136	0	31	30
2015	7	24	6	56	52	0.19	0.016	0.879	0.039	0.036	0	45.2	44.7	70.5	135	133	0	30	29
2015	7	24	7	6	52	0.108	-0.043	0.879	0.039	0.039	0	44.7	43	71	134	130	0	30	30
2015	7	24	7	16	52	0.21	-0.02	0.879	0.033	0.03	0	45.2	43.9	71.4	135	132	0	30	30
2015	7	24	7	26	52	0.151	0.013	0.883	0.039	0.039	0	44.7	44.3	72.2	134	132	0	30	29
2015	7	24	7	36	52	0.187	0	0.883	0.033	0.03	0	44.7	43.9	71.8	135	132	0	31	30
2015	7	24	7	46	52	0.2	-0.036	0.883	0.036	0.033	0	44.7	44.7	71.8	135	134	0	31	30
2015	7	24	7	56	52	0.164	-0.02	0.883	0.049	0.046	0	44.7	44.3	71.8	135	133	0	31	30
2015	7	24	8	6	52	0.236	-0.02	0.883	0.039	0.036	0	48.2	46.9	69.2	142	139	0	30	30
2015	7	24	8	16	52	0.154	-0.003	0.883	0.046	0.043	0	46.4	44.7	71.4	139	134	0	31	30
2015	7	24	8	26	52	0.256	0	0.883	0.036	0.033	0	47.3	46.4	70.1	140	138	0	30	30
2015	7	24	8	36	52	0.194	0.01	0.883	0.033	0.03	0	46	44.7	72.2	138	134	0	31	30
2015	7	24	8	46	52	0.276	-0.02	0.883	0.036	0.033	0	46.4	45.2	71.8	139	135	0	31	30
2015	7	24	8	56	52	0.154	0.003	0.883	0.039	0.036	0	46.4	45.6	71.4	139	136	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	24	9	6	52	0.184	-0.039	0.883	0.039	0.036	0	47.3	46.9	71	141	139	0	31	30
2015	7	24	9	16	52	0.177	-0.026	0.883	0.046	0.043	0	47.7	47.7	69.7	142	140	0	31	29
2015	7	24	9	26	52	0.164	0.023	0.886	0.039	0.036	0	47.3	46	71	140	136	0	30	29
2015	7	24	9	36	52	0.174	0	0.886	0.039	0.036	0	45.2	44.7	73.5	136	134	0	31	30
2015	7	24	9	46	52	0.187	0.033	0.886	0.039	0.036	0	46	45.6	72.2	138	135	0	31	29
2015	7	24	9	56	52	0.171	-0.033	0.886	0.033	0.03	0	46.4	46.4	71.4	139	138	0	31	30
2015	7	24	10	6	52	0.184	0.069	0.886	0.033	0.03	0	47.3	46	71.8	141	137	0	31	30
2015	7	24	10	16	52	0.194	-0.003	0.886	0.039	0.039	0	48.6	46.9	71.4	143	139	0	30	30
2015	7	24	10	26	52	0.24	0	0.886	0.039	0.039	0	47.3	46.9	71.8	140	139	0	30	30
2015	7	24	10	36	52	0.118	0.007	0.886	0.036	0.033	0	48.6	47.7	71	144	140	0	31	29
2015	7	24	10	46	52	0.177	0	0.886	0.033	0.03	0	46	46.9	72.7	137	139	0	30	30
2015	7	24	10	56	52	0.174	0.079	0.886	0.036	0.033	0	46.4	46.9	73.1	138	138	0	30	29
2015	7	24	11	6	52	0.171	-0.049	0.886	0.033	0.03	0	46	46.9	72.7	138	139	0	31	30
2015	7	24	11	16	52	0.23	0.016	0.886	0.036	0.033	0	46.9	47.7	71.8	140	141	0	31	30
2015	7	24	11	26	52	0.141	0.036	0.886	0.036	0.033	0	47.7	48.2	71.4	141	141	0	30	29
2015	7	24	11	36	52	0.144	-0.02	0.886	0.033	0.03	0	50.7	50.3	67.9	148	146	0	30	29
2015	7	24	11	46	52	0.22	0	0.886	0.033	0.03	0	50.3	49.9	68.8	147	146	0	30	30
2015	7	24	11	56	52	0.194	-0.02	0.886	0.039	0.036	0	52.5	51.2	67.5	152	148	0	30	29
2015	7	24	12	6	52	0.203	0	0.886	0.033	0.03	0	52	51.2	67.9	151	149	0	30	30
2015	7	24	12	16	52	0.197	0.039	0.886	0.036	0.033	0	50.3	50.3	69.2	147	147	0	30	30
2015	7	24	12	26	52	0.174	-0.013	0.886	0.036	0.033	0	50.3	50.3	68.8	148	147	0	31	30
2015	7	24	12	36	52	0.174	0.056	0.886	0.039	0.036	0	51.6	51.2	67.9	150	148	0	30	29
2015	7	24	12	46	52	0.328	-0.026	0.886	0.033	0.03	0	51.6	50.7	68.8	150	147	0	30	29
2015	7	24	12	56	52	0.167	0.026	0.886	0.036	0.033	0	50.7	51.2	68.4	149	148	0	31	29
2015	7	24	13	6	52	0.19	0.079	0.886	0.033	0.03	0	51.6	52.5	68.4	150	152	0	30	30
2015	7	24	13	16	52	0.171	0.062	0.886	0.039	0.039	0	52.5	52	67.1	152	151	0	30	30
2015	7	24	13	26	52	0.174	0.016	0.886	0.033	0.03	0	52.9	52.5	66.7	153	151	0	30	29
2015	7	24	13	36	52	0.269	0.016	0.886	0.039	0.036	0	51.6	52	67.5	150	150	0	30	29
2015	7	24	13	46	52	0.171	0.013	0.886	0.033	0.03	0	55.5	53.8	65.4	159	154	0	30	29
2015	7	24	13	56	52	0.223	0.003	0.886	0.039	0.039	0	52	52	67.1	151	151	0	30	30
2015	7	24	14	6	52	0.161	0.089	0.886	0.033	0.03	0	53.8	52.9	66.2	155	153	0	30	30
2015	7	24	14	16	52	0.177	0.128	0.886	0.033	0.03	0	52.5	52.9	67.1	152	152	0	30	29
2015	7	24	14	26	52	0.2	0.026	0.886	0.036	0.033	0	53.3	52.9	66.7	154	152	0	30	29
2015	7	24	14	36	52	0.226	0.075	0.886	0.033	0.03	0	55	54.2	65.4	158	155	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	24	14	46	52	0.213	0.085	0.883	0.043	0.039	0	55.5	54.6	63.6	159	157	0	30	30
2015	7	24	14	56	52	0.135	0.102	0.886	0.039	0.036	0	55.5	54.6	62.4	159	156	0	30	29
2015	7	24	15	6	52	0.203	0.164	0.886	0.043	0.039	0	55.5	54.6	64.1	159	156	0	30	29
2015	7	24	15	16	52	0.217	0.112	0.883	0.036	0.033	0	54.6	54.2	64.1	157	155	0	30	29
2015	7	24	15	26	52	0.23	0.112	0.886	0.033	0.03	0	54.2	54.2	63.6	157	155	0	31	29
2015	7	24	15	36	52	0.233	0.154	0.883	0.046	0.043	0	55	54.2	64.5	158	155	0	30	29
2015	7	24	15	46	52	0.197	0.118	0.886	0.036	0.033	0	54.2	53.8	63.6	157	155	0	31	30
2015	7	24	15	56	52	0.203	0.154	0.886	0.036	0.033	0	53.8	53.3	65.4	155	153	0	30	29
2015	7	24	16	6	52	0.246	0.161	0.886	0.043	0.043	0	53.3	52.5	65.8	154	151	0	30	29
2015	7	24	16	16	52	0.217	0.144	0.886	0.036	0.033	0	52.5	51.6	67.1	152	149	0	30	29
2015	7	24	16	26	52	0.177	0.082	0.883	0.036	0.033	0	52	52.5	66.2	151	151	0	30	29
2015	7	24	16	36	52	0.246	0.112	0.886	0.036	0.033	0	51.6	51.6	66.2	150	149	0	30	29
2015	7	24	16	46	52	0.157	0.046	0.886	0.033	0.03	0	51.6	50.7	68.8	149	147	0	29	29
2015	7	24	16	56	52	0.174	-0.007	0.886	0.033	0.03	0	51.6	50.3	67.1	150	146	0	30	29
2015	7	24	17	6	52	0.21	0.092	0.886	0.033	0.03	0	50.3	49.5	69.2	147	144	0	30	29
2015	7	24	17	16	52	0.197	0.046	0.886	0.036	0.033	0	49.9	49.5	68.4	146	144	0	30	29
2015	7	24	17	26	52	0.22	0.023	0.886	0.039	0.036	0	49	48.6	68.8	144	143	0	30	30
2015	7	24	17	36	52	0.161	0.02	0.886	0.039	0.036	0	49	49	68.8	144	143	0	30	29
2015	7	24	17	46	52	0.22	0.052	0.886	0.036	0.033	0	51.6	49.9	66.7	149	146	0	29	30
2015	7	24	17	56	52	0.226	0.056	0.886	0.043	0.039	0	54.2	52.9	63.2	156	152	0	30	29
2015	7	24	18	6	52	0.161	0.033	0.886	0.036	0.033	0	53.3	51.6	63.6	153	149	0	29	29
2015	7	24	18	16	52	0.131	-0.007	0.886	0.039	0.039	0	50.3	49.5	66.2	147	144	0	30	29
2015	7	24	18	26	52	0.174	-0.007	0.886	0.039	0.036	0	52.9	51.6	63.6	153	149	0	30	29
2015	7	24	18	36	52	0.246	-0.02	0.889	0.039	0.039	0	47.3	46	70.1	140	136	0	30	29
2015	7	24	18	46	52	0.157	-0.02	0.886	0.036	0.033	0	52	49.9	64.9	150	145	0	29	29
2015	7	24	18	56	52	0.23	-0.046	0.886	0.043	0.039	0	51.6	49.9	65.4	150	145	0	30	29
2015	7	24	19	6	52	0.167	-0.01	0.886	0.036	0.033	0	52.9	51.2	64.9	153	148	0	30	29
2015	7	24	19	16	52	0.19	0.026	0.889	0.039	0.039	0	50.7	49	66.7	148	143	0	30	29
2015	7	24	19	26	52	0.131	0	0.889	0.039	0.039	0	52.9	51.2	64.5	153	148	0	30	29
2015	7	24	19	36	52	0.177	0.026	0.889	0.039	0.039	0	53.3	51.2	64.9	154	148	0	30	29
2015	7	24	19	46	52	0.128	-0.003	0.889	0.043	0.039	0	49.5	48.2	69.2	145	140	0	30	28
2015	7	24	19	56	52	0.259	-0.056	0.889	0.033	0.03	0	52.5	50.3	65.4	152	146	0	30	29
2015	7	24	20	6	52	0.151	0.01	0.889	0.039	0.039	0	51.6	49.9	66.7	149	144	0	29	28
2015	7	24	20	16	52	0.171	0.013	0.889	0.039	0.039	0	49.5	48.6	68.4	145	141	0	30	28

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	24	20	26	52	0.21	-0.036	0.889	0.039	0.036	0	49	47.7	69.2	144	140	0	30	29
2015	7	24	20	36	52	0.171	0.013	0.889	0.039	0.036	0	47.3	46	70.5	140	136	0	30	29
2015	7	24	20	46	52	0.197	0.013	0.892	0.036	0.033	0	45.6	45.6	72.2	137	135	0	31	29
2015	7	24	20	56	52	0.217	-0.016	0.892	0.039	0.036	0	46.4	45.6	71	138	135	0	30	29
2015	7	24	21	6	52	0.138	-0.049	0.892	0.039	0.036	0	46.4	45.2	71.8	138	134	0	30	29
2015	7	24	21	16	52	0.21	0.075	0.892	0.036	0.033	0	46	44.7	72.7	137	133	0	30	29
2015	7	24	21	26	52	0.197	0.016	0.892	0.039	0.036	0	47.3	45.6	71.8	140	135	0	30	29
2015	7	24	21	36	52	0.154	-0.059	0.892	0.039	0.039	0	46	44.7	72.7	137	133	0	30	29
2015	7	24	21	46	52	0.203	0.016	0.892	0.039	0.036	0	46	45.2	72.2	137	134	0	30	29
2015	7	24	21	56	52	0.203	-0.036	0.892	0.036	0.033	0	46.4	44.3	73.1	138	133	0	30	30
2015	7	24	22	6	52	0.21	-0.023	0.892	0.036	0.033	0	46	44.7	73.1	137	133	0	30	29
2015	7	24	22	16	52	0.154	-0.049	0.892	0.036	0.033	0	46.9	45.6	72.7	139	135	0	30	29
2015	7	24	22	26	52	0.118	-0.013	0.892	0.039	0.036	0	46.4	45.6	71.8	138	135	0	30	29
2015	7	24	22	36	52	0.194	0.075	0.892	0.039	0.039	0	45.2	43.9	74.4	134	131	0	29	29
2015	7	24	22	46	52	0.226	0.03	0.892	0.043	0.039	0	46.4	44.7	74	138	133	0	30	29
2015	7	24	22	56	52	0.226	-0.036	0.892	0.036	0.033	0	44.3	43.4	75.3	133	131	0	30	30
2015	7	24	23	6	52	0.236	0	0.892	0.039	0.036	0	45.2	43.4	74.8	135	130	0	30	29
2015	7	24	23	16	52	0.148	-0.052	0.892	0.039	0.039	0	44.3	43.4	74.8	134	130	0	31	29
2015	7	24	23	26	52	0.18	-0.036	0.892	0.036	0.033	0	44.7	43.9	75.3	134	131	0	30	29
2015	7	24	23	36	52	0.062	-0.007	0.892	0.039	0.039	0	45.2	43.9	74.4	135	132	0	30	30
2015	7	24	23	46	52	0.151	-0.02	0.892	0.039	0.036	0	44.7	43	74.8	134	130	0	30	30
2015	7	24	23	56	52	0.285	0.03	0.892	0.039	0.039	0	44.7	43.4	75.3	134	130	0	30	29
2015	7	25	0	6	52	0.131	0.016	0.892	0.036	0.033	0	45.2	44.3	74.8	135	132	0	30	29
2015	7	25	0	16	52	0.128	0	0.892	0.039	0.039	0	45.6	44.3	74	136	132	0	30	29
2015	7	25	0	26	52	0.18	-0.056	0.892	0.033	0.03	0	44.3	43.4	75.7	133	130	0	30	29
2015	7	25	0	36	52	0.184	0.02	0.892	0.039	0.039	0	44.7	42.6	74.8	134	129	0	30	30
2015	7	25	0	46	52	0.21	-0.043	0.892	0.033	0.03	0	45.2	43.9	74.4	135	131	0	30	29
2015	7	25	0	56	52	0.167	-0.016	0.892	0.039	0.036	0	44.3	43.9	75.7	133	131	0	30	29
2015	7	25	1	6	52	0.167	0.039	0.892	0.033	0.03	0	45.2	44.3	74.8	135	132	0	30	29
2015	7	25	1	16	52	0.174	-0.046	0.892	0.039	0.036	0	44.3	43.4	75.7	133	130	0	30	29
2015	7	25	1	26	52	0.213	0.013	0.892	0.039	0.039	0	45.2	43.4	74.4	135	131	0	30	30
2015	7	25	1	36	52	0.223	0.046	0.892	0.036	0.033	0	45.6	44.3	75.3	136	132	0	30	29
2015	7	25	1	46	52	0.203	-0.007	0.892	0.043	0.039	0	43.9	43	76.1	132	130	0	30	30
2015	7	25	1	56	52	0.203	-0.062	0.892	0.039	0.039	0	44.3	43.9	75.3	134	132	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	25	2	6	52	0.157	-0.036	0.892	0.039	0.039	0	45.2	43.4	75.7	135	130	0	30	29
2015	7	25	2	16	52	0.187	-0.016	0.892	0.039	0.036	0	44.3	43	76.1	133	130	0	30	30
2015	7	25	2	26	52	0.174	0.016	0.892	0.043	0.039	0	43.9	43.4	76.1	132	130	0	30	29
2015	7	25	2	36	52	0.141	-0.007	0.892	0.036	0.033	0	45.2	43.4	75.7	135	131	0	30	30
2015	7	25	2	46	52	0.184	0.003	0.892	0.039	0.039	0	43.4	43.4	75.3	131	131	0	30	30
2015	7	25	2	56	52	0.194	0.02	0.892	0.039	0.036	0	46.4	45.2	74.4	138	134	0	30	29
2015	7	25	3	6	52	0.276	-0.03	0.892	0.043	0.039	0	45.2	44.3	75.7	135	132	0	30	29
2015	7	25	3	16	52	0.18	0	0.892	0.033	0.03	0	46	46	74	138	136	0	31	29
2015	7	25	3	26	52	0.194	-0.082	0.892	0.039	0.036	0	43.9	43	76.5	132	130	0	30	30
2015	7	25	3	36	52	0.203	-0.016	0.892	0.039	0.039	0	45.6	44.3	75.3	136	132	0	30	29
2015	7	25	3	46	52	0.223	0.007	0.892	0.036	0.033	0	44.7	44.3	76.1	135	132	0	31	29
2015	7	25	3	56	52	0.18	-0.036	0.892	0.033	0.03	0	45.6	44.7	74.4	136	133	0	30	29
2015	7	25	4	6	52	0.128	-0.03	0.892	0.036	0.033	0	46.9	45.6	74.4	139	135	0	30	29
2015	7	25	4	16	52	0.2	-0.03	0.892	0.033	0.03	0	45.2	44.3	75.7	135	133	0	30	30
2015	7	25	4	26	52	0.174	0.013	0.892	0.039	0.036	0	44.3	43.9	76.1	133	131	0	30	29
2015	7	25	4	36	52	0.144	-0.01	0.892	0.036	0.033	0	44.3	43.4	76.5	134	131	0	31	30
2015	7	25	4	46	52	0.236	0.075	0.892	0.033	0.03	0	45.6	45.2	74.4	137	135	0	31	30
2015	7	25	4	56	52	0.24	0.02	0.892	0.036	0.033	0	46.9	45.2	74	139	136	0	30	31
2015	7	25	5	6	52	0.24	0	0.892	0.043	0.039	0	46	44.3	75.3	137	133	0	30	30
2015	7	25	5	16	52	0.223	0.03	0.892	0.039	0.036	0	45.6	44.7	74.4	136	134	0	30	30
2015	7	25	5	26	52	0.243	-0.01	0.892	0.039	0.039	0	45.2	44.3	75.3	136	132	0	31	29
2015	7	25	5	36	52	0.164	0.016	0.892	0.046	0.043	0	45.6	44.3	75.3	137	133	0	31	30
2015	7	25	5	46	52	0.2	-0.039	0.892	0.036	0.033	0	49.5	48.2	71	145	141	0	30	29
2015	7	25	5	56	52	0.082	-0.026	0.892	0.036	0.033	0	47.7	46	72.7	141	137	0	30	30
2015	7	25	6	6	52	0.164	-0.056	0.892	0.039	0.036	0	45.6	44.3	74	137	133	0	31	30
2015	7	25	6	16	52	0.128	-0.075	0.892	0.039	0.036	0	43.4	42.1	76.5	131	128	0	30	30
2015	7	25	6	26	52	0.144	-0.056	0.892	0.033	0.03	0	45.6	43	75.7	136	130	0	30	30
2015	7	25	6	36	52	0.131	-0.036	0.892	0.049	0.046	0	43.4	42.1	76.1	132	128	0	31	30
2015	7	25	6	46	52	0.177	-0.059	0.892	0.046	0.046	0	44.7	43.9	74.8	135	132	0	31	30
2015	7	25	6	56	52	0.2	-0.052	0.892	0.039	0.039	0	43.4	41.7	77	131	127	0	30	30
2015	7	25	7	6	52	0.187	0.01	0.892	0.033	0.03	0	43.4	41.7	77.4	131	127	0	30	30
2015	7	25	7	16	52	0.157	-0.079	0.892	0.033	0.033	0	43	41.7	77	130	127	0	30	30
2015	7	25	7	26	52	0.105	-0.059	0.892	0.046	0.043	0	44.3	43	76.1	133	130	0	30	30
2015	7	25	7	36	52	0.161	-0.056	0.892	0.039	0.036	0	44.7	43.9	75.3	135	132	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	25	7	46	52	0.154	-0.056	0.892	0.036	0.033	0	48.2	47.3	72.2	142	139	0	30	29
2015	7	25	7	56	52	0.289	-0.075	0.892	0.039	0.036	0	42.1	42.1	76.5	129	128	0	31	30
2015	7	25	8	6	52	0.23	0.052	0.892	0.039	0.039	0	46	43.9	76.1	137	131	0	30	29
2015	7	25	8	16	52	0.187	-0.033	0.892	0.049	0.046	0	43.4	43.4	76.1	132	131	0	31	30
2015	7	25	8	26	52	0.164	-0.03	0.892	0.033	0.03	0	44.7	43.4	76.5	134	131	0	30	30
2015	7	25	8	36	52	0.174	-0.036	0.896	0.033	0.03	0	44.3	43.4	77	134	131	0	31	30
2015	7	25	8	46	52	0.226	-0.043	0.892	0.036	0.033	0	45.2	45.2	75.7	136	135	0	31	30
2015	7	25	8	56	52	0.217	-0.003	0.892	0.036	0.033	0	46.4	45.2	76.1	138	134	0	30	29
2015	7	25	9	6	52	0.217	0.02	0.896	0.039	0.039	0	47.3	46	74.8	140	137	0	30	30
2015	7	25	9	16	52	0.18	0.03	0.892	0.039	0.036	0	47.3	46	75.7	140	137	0	30	30
2015	7	25	9	26	52	0.203	-0.033	0.896	0.036	0.033	0	46	45.2	75.7	137	135	0	30	30
2015	7	25	9	36	52	0.187	-0.01	0.896	0.033	0.03	0	45.6	45.2	76.1	137	135	0	31	30
2015	7	25	9	46	52	0.2	-0.052	0.896	0.033	0.03	0	46.4	46.9	74.4	139	138	0	31	29
2015	7	25	9	56	52	0.141	0.039	0.892	0.039	0.036	0	46	45.6	75.7	137	136	0	30	30
2015	7	25	10	6	52	0.249	0.036	0.892	0.039	0.039	0	47.3	46.4	75.3	140	138	0	30	30
2015	7	25	10	16	52	0.177	0.01	0.892	0.036	0.033	0	46	46.9	75.3	138	139	0	31	30
2015	7	25	10	26	52	0.217	0.043	0.896	0.036	0.033	0	47.3	47.3	75.7	141	140	0	31	30
2015	7	25	10	36	52	0.203	0.066	0.892	0.033	0.03	0	46.9	48.2	75.7	139	142	0	30	30
2015	7	25	10	46	52	0.226	0.059	0.892	0.036	0.033	0	47.3	47.3	74.4	141	141	0	31	31
2015	7	25	10	56	52	0.167	0.026	0.892	0.036	0.033	0	46.9	48.6	74.8	140	142	0	31	29
2015	7	25	11	6	52	0.197	-0.02	0.892	0.03	0.03	0	48.2	48.6	74	142	143	0	30	30
2015	7	25	11	16	52	0.213	0.016	0.892	0.033	0.03	0	49	49.5	73.1	144	145	0	30	30
2015	7	25	11	26	52	0.203	0.062	0.892	0.033	0.03	0	48.6	50.3	72.2	143	147	0	30	30
2015	7	25	11	36	52	0.194	0.112	0.892	0.039	0.036	0	48.6	50.3	70.5	143	146	0	30	29
2015	7	25	11	46	52	0.18	0.013	0.892	0.036	0.033	0	49.9	51.2	71	146	149	0	30	30
2015	7	25	11	56	52	0.213	0.023	0.892	0.033	0.03	0	49.5	51.6	71.4	145	149	0	30	29
2015	7	25	12	6	52	0.164	0.085	0.889	0.033	0.03	0	50.7	51.6	70.1	148	150	0	30	30
2015	7	25	12	16	52	0.2	0.033	0.889	0.033	0.03	0	51.6	52.5	69.7	150	151	0	30	29
2015	7	25	12	26	52	0.223	0.03	0.889	0.033	0.03	0	52.5	52.5	68.4	152	152	0	30	30
2015	7	25	12	36	52	0.223	0.039	0.889	0.03	0.03	0	51.6	52.9	68.4	151	152	0	31	29
2015	7	25	12	46	52	0.184	0.148	0.889	0.033	0.03	0	52.5	52.9	68.4	152	152	0	30	29
2015	7	25	12	56	52	0.2	0.036	0.889	0.033	0.03	0	52.5	54.2	69.2	153	155	0	31	29
2015	7	25	13	6	52	0.217	0.066	0.889	0.033	0.03	0	52.5	52.9	68.8	152	153	0	30	30
2015	7	25	13	16	52	0.256	0.066	0.889	0.036	0.033	0	52.5	54.2	67.9	153	155	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	25	13	26	52	0.246	0.052	0.889	0.036	0.033	0	52.5	53.8	67.1	153	154	0	31	29
2015	7	25	13	36	52	0.19	0.046	0.889	0.033	0.03	0	53.3	54.2	67.1	154	155	0	30	29
2015	7	25	13	46	52	0.164	0.092	0.889	0.033	0.03	0	52.9	54.2	68.4	153	155	0	30	29
2015	7	25	13	56	52	0.187	0.046	0.889	0.033	0.03	0	53.8	54.2	66.2	155	156	0	30	30
2015	7	25	14	6	52	0.151	-0.016	0.889	0.036	0.033	0	53.3	54.6	67.5	154	156	0	30	29
2015	7	25	14	16	52	0.23	0.105	0.886	0.033	0.03	0	53.8	54.6	66.2	155	156	0	30	29
2015	7	25	14	26	52	0.21	0.016	0.889	0.033	0.03	0	53.3	54.2	66.7	154	155	0	30	29
2015	7	25	14	36	52	0.187	0.056	0.889	0.033	0.03	0	53.3	54.2	65.8	155	155	0	31	29
2015	7	25	14	46	52	0.21	0.079	0.889	0.036	0.033	0	54.2	54.6	65.8	156	156	0	30	29
2015	7	25	14	56	52	0.18	0.079	0.886	0.033	0.03	0	53.8	54.6	66.7	155	156	0	30	29
2015	7	25	15	6	52	0.164	0.03	0.886	0.033	0.033	0	53.3	54.6	67.1	154	156	0	30	29
2015	7	25	15	16	52	0.197	0.052	0.886	0.033	0.03	0	53.8	54.2	66.7	155	155	0	30	29
2015	7	25	15	26	52	0.21	0.125	0.886	0.033	0.03	0	54.2	54.2	65.8	156	155	0	30	29
2015	7	25	15	36	52	0.2	0.056	0.886	0.033	0.03	0	54.6	54.6	66.7	157	156	0	30	29
2015	7	25	15	46	52	0.217	0.056	0.886	0.033	0.03	0	52.5	54.2	67.1	152	155	0	30	29
2015	7	25	15	56	52	0.18	0.013	0.886	0.033	0.03	0	53.8	53.8	65.8	155	154	0	30	29
2015	7	25	16	6	52	0.174	0	0.886	0.036	0.033	0	52.9	53.3	66.7	153	153	0	30	29
2015	7	25	16	16	52	0.141	-0.007	0.883	0.033	0.03	0	53.8	53.3	66.7	155	153	0	30	29
2015	7	25	16	26	52	0.177	-0.003	0.883	0.033	0.03	0	53.8	52.9	65.4	155	152	0	30	29
2015	7	25	16	36	52	0.18	0	0.886	0.033	0.03	0	52.9	52.5	67.1	153	151	0	30	29
2015	7	25	16	46	52	0.19	0.075	0.886	0.036	0.033	0	51.6	52.5	66.7	150	151	0	30	29
2015	7	25	16	56	52	0.217	0.039	0.886	0.039	0.036	0	52	51.6	64.9	151	149	0	30	29
2015	7	25	17	6	52	0.161	0.072	0.883	0.039	0.036	0	51.2	51.6	67.5	149	149	0	30	29
2015	7	25	17	16	52	0.154	0.003	0.883	0.043	0.039	0	51.6	50.3	67.1	149	147	0	29	30
2015	7	25	17	26	52	0.272	0.082	0.886	0.033	0.03	0	49.9	49.5	68.8	146	144	0	30	29
2015	7	25	17	36	52	0.19	0.108	0.883	0.039	0.036	0	48.2	49	70.1	142	142	0	30	28
2015	7	25	17	46	52	0.161	0.02	0.883	0.033	0.03	0	47.3	47.3	70.5	140	139	0	30	29
2015	7	25	17	56	52	0.18	-0.03	0.886	0.033	0.03	0	47.3	46.9	70.1	140	138	0	30	29
2015	7	25	18	6	52	0.171	-0.003	0.886	0.036	0.033	0	46.4	46	70.5	138	136	0	30	29
2015	7	25	18	16	52	0.246	0.072	0.886	0.033	0.03	0	45.2	44.3	70.5	135	132	0	30	29
2015	7	25	18	26	52	0.144	-0.059	0.886	0.033	0.03	0	45.6	44.3	71.4	136	132	0	30	29
2015	7	25	18	36	52	0.171	0	0.886	0.036	0.033	0	44.3	43	71.4	133	129	0	30	29
2015	7	25	18	46	52	0.141	0.03	0.886	0.033	0.03	0	43.9	42.6	72.7	131	128	0	29	29
2015	7	25	18	56	52	0.148	-0.023	0.886	0.039	0.036	0	43.9	43	72.2	132	129	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	25	19	6	52	0.141	0	0.886	0.036	0.033	0	44.3	42.6	72.2	133	128	0	30	29
2015	7	25	19	16	52	0.243	0	0.886	0.039	0.036	0	43.9	43	71.8	132	129	0	30	29
2015	7	25	19	26	52	0.23	-0.033	0.886	0.033	0.03	0	44.3	43.9	72.2	134	131	0	31	29
2015	7	25	19	36	52	0.184	0.016	0.886	0.039	0.036	0	46.9	45.2	70.1	139	134	0	30	29
2015	7	25	19	46	52	0.151	-0.079	0.886	0.036	0.033	0	44.7	44.3	71.4	135	132	0	31	29
2015	7	25	19	56	52	0.203	-0.02	0.886	0.036	0.033	0	45.6	44.3	71.4	135	132	0	29	29
2015	7	25	20	6	52	0.194	-0.079	0.886	0.043	0.039	0	46.9	45.2	70.5	138	133	0	29	28
2015	7	25	20	16	52	0.164	0.016	0.886	0.036	0.033	0	46	44.7	70.5	137	133	0	30	29
2015	7	25	20	26	52	0.19	0.013	0.883	0.036	0.033	0	53.3	51.2	63.6	154	149	0	30	30
2015	7	25	20	36	52	0.194	-0.089	0.886	0.039	0.039	0	47.3	45.2	70.1	140	134	0	30	29
2015	7	25	20	46	52	0.135	-0.092	0.886	0.039	0.039	0	49.9	48.6	67.5	146	142	0	30	29
2015	7	25	20	56	52	0.167	-0.033	0.886	0.039	0.039	0	49.9	48.2	67.1	146	141	0	30	29
2015	7	25	21	6	52	0.194	-0.026	0.886	0.036	0.033	0	48.2	45.6	69.7	141	135	0	29	29
2015	7	25	21	16	52	0.22	-0.02	0.886	0.033	0.03	0	46.9	45.6	70.5	139	135	0	30	29
2015	7	25	21	26	52	0.171	-0.062	0.886	0.036	0.033	0	48.2	46.9	69.2	142	138	0	30	29
2015	7	25	21	36	52	0.217	0	0.889	0.039	0.039	0	45.2	43.9	72.2	135	132	0	30	30
2015	7	25	21	46	52	0.21	0.049	0.889	0.039	0.039	0	44.7	44.3	71.4	135	133	0	31	30
2015	7	25	21	56	52	0.151	0	0.886	0.039	0.036	0	45.2	44.7	71.8	136	133	0	31	29
2015	7	25	22	6	52	0.167	0.01	0.886	0.039	0.036	0	46.9	45.6	70.1	139	136	0	30	30
2015	7	25	22	16	52	0.207	0.056	0.889	0.039	0.039	0	46	45.2	71.8	137	134	0	30	29
2015	7	25	22	26	52	0.167	-0.026	0.886	0.043	0.039	0	46	45.2	71.8	137	134	0	30	29
2015	7	25	22	36	52	0.246	-0.02	0.889	0.039	0.036	0	47.3	46.4	70.5	140	137	0	30	29
2015	7	25	22	46	52	0.213	-0.023	0.886	0.036	0.033	0	46	45.2	71	137	134	0	30	29
2015	7	25	22	56	52	0.184	-0.066	0.889	0.039	0.036	0	46.4	45.6	71.4	138	135	0	30	29
2015	7	25	23	6	52	0.23	0.013	0.889	0.039	0.036	0	46.4	44.7	71.8	138	133	0	30	29
2015	7	25	23	16	52	0.233	-0.056	0.886	0.039	0.036	0	46.9	44.3	71.8	139	133	0	30	30
2015	7	25	23	26	52	0.203	-0.02	0.889	0.039	0.036	0	46.9	45.6	71.4	139	135	0	30	29
2015	7	25	23	36	52	0.161	-0.016	0.889	0.033	0.03	0	46.4	45.2	71.4	138	134	0	30	29
2015	7	25	23	46	52	0.187	-0.03	0.889	0.039	0.039	0	45.2	44.3	73.5	135	132	0	30	29
2015	7	25	23	56	52	0.207	0.046	0.889	0.033	0.033	0	45.2	43	72.7	135	130	0	30	30
2015	7	26	0	6	52	0.187	0.089	0.889	0.039	0.036	0	45.6	43.9	72.7	136	132	0	30	30
2015	7	26	0	16	52	0.194	-0.033	0.886	0.039	0.036	0	46.4	45.6	72.7	138	135	0	30	29
2015	7	26	0	26	52	0.161	0	0.889	0.039	0.036	0	45.6	43.9	73.5	136	131	0	30	29
2015	7	26	0	36	52	0.203	0.013	0.889	0.033	0.03	0	45.6	44.3	73.5	136	132	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	26	0	46	52	0.167	-0.023	0.889	0.039	0.039	0	44.7	43.9	72.7	134	132	0	30	30
2015	7	26	0	56	52	0.197	-0.007	0.889	0.039	0.036	0	45.2	43.9	73.5	135	132	0	30	30
2015	7	26	1	6	52	0.253	-0.056	0.889	0.039	0.036	0	46.9	45.2	71.8	139	135	0	30	30
2015	7	26	1	16	52	0.167	-0.108	0.889	0.033	0.03	0	44.3	43.9	73.5	133	131	0	30	29
2015	7	26	1	26	52	0.217	0.01	0.889	0.043	0.039	0	45.2	44.3	73.1	135	133	0	30	30
2015	7	26	1	36	52	0.161	-0.026	0.889	0.039	0.036	0	44.3	43	74.4	134	129	0	31	29
2015	7	26	1	46	52	0.151	-0.069	0.889	0.039	0.039	0	45.2	43	74.8	135	130	0	30	30
2015	7	26	1	56	52	0.148	-0.049	0.889	0.039	0.036	0	43.4	43	74.8	131	129	0	30	29
2015	7	26	2	6	52	0.177	-0.033	0.886	0.036	0.033	0	46.4	45.2	71.4	139	135	0	31	30
2015	7	26	2	16	52	0.135	0	0.889	0.039	0.036	0	43.9	43	74	133	130	0	31	30
2015	7	26	2	26	52	0.151	-0.03	0.889	0.033	0.03	0	45.2	44.3	73.1	135	132	0	30	29
2015	7	26	2	36	52	0.187	0.089	0.889	0.033	0.03	0	44.3	43.4	74.4	133	130	0	30	29
2015	7	26	2	46	52	0.174	0	0.889	0.039	0.036	0	43.9	43	74.8	132	130	0	30	30
2015	7	26	2	56	52	0.22	0	0.889	0.036	0.033	0	44.3	43	74.8	133	130	0	30	30
2015	7	26	3	6	52	0.157	0.023	0.889	0.039	0.036	0	44.3	43.4	73.5	133	131	0	30	30
2015	7	26	3	16	52	0.164	0	0.889	0.033	0.03	0	42.6	42.1	75.3	130	128	0	31	30
2015	7	26	3	26	52	0.167	-0.007	0.889	0.043	0.039	0	44.7	43	74.4	134	130	0	30	30
2015	7	26	3	36	52	0.259	-0.062	0.889	0.039	0.039	0	43.4	42.1	74.8	131	128	0	30	30
2015	7	26	3	46	52	0.108	0	0.889	0.039	0.036	0	44.3	43	74.4	133	130	0	30	30
2015	7	26	3	56	52	0.18	-0.013	0.889	0.039	0.039	0	43.4	43.4	74	132	130	0	31	29
2015	7	26	4	6	52	0.203	0.003	0.889	0.039	0.039	0	45.6	44.3	73.5	136	132	0	30	29
2015	7	26	4	16	52	0.24	-0.02	0.889	0.036	0.033	0	44.3	43	74.8	133	130	0	30	30
2015	7	26	4	26	52	0.2	-0.023	0.889	0.036	0.033	0	43	42.6	75.3	131	129	0	31	30
2015	7	26	4	36	52	0.141	0	0.889	0.036	0.033	0	44.3	44.3	74.8	133	132	0	30	29
2015	7	26	4	46	52	0.187	-0.059	0.889	0.036	0.033	0	44.7	43.4	74.8	134	130	0	30	29
2015	7	26	4	56	52	0.184	-0.069	0.889	0.036	0.033	0	44.7	43.4	74.8	134	131	0	30	30
2015	7	26	5	6	52	0.226	-0.059	0.889	0.039	0.039	0	44.3	43.4	74.8	133	131	0	30	30
2015	7	26	5	16	52	0.19	0.039	0.889	0.036	0.033	0	44.3	43.4	74.4	134	131	0	31	30
2015	7	26	5	26	52	0.161	0.026	0.889	0.039	0.039	0	45.2	44.7	73.5	136	133	0	31	29
2015	7	26	5	36	52	0.197	-0.079	0.889	0.036	0.033	0	45.2	43.9	74.4	135	132	0	30	30
2015	7	26	5	46	52	0.22	-0.03	0.889	0.039	0.036	0	45.2	44.3	73.5	136	133	0	31	30
2015	7	26	5	56	52	0.161	0.003	0.889	0.039	0.036	0	47.7	46.9	70.5	142	139	0	31	30
2015	7	26	6	6	52	0.157	0	0.889	0.039	0.039	0	47.7	46.9	71	142	139	0	31	30
2015	7	26	6	16	52	0.177	-0.033	0.889	0.039	0.039	0	46.9	45.6	72.2	140	136	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	26	6	26	52	0.187	-0.066	0.889	0.043	0.039	0	46.4	45.2	73.1	139	134	0	31	29
2015	7	26	6	36	52	0.148	-0.016	0.889	0.039	0.039	0	44.3	44.3	74.8	133	132	0	30	29
2015	7	26	6	46	52	0.23	-0.052	0.889	0.036	0.033	0	43.4	42.6	75.3	132	129	0	31	30
2015	7	26	6	56	52	0.207	-0.046	0.889	0.036	0.033	0	43.4	42.1	75.7	131	128	0	30	30
2015	7	26	7	6	52	0.18	-0.033	0.889	0.039	0.036	0	43	42.1	75.7	131	128	0	31	30
2015	7	26	7	16	52	0.223	-0.089	0.889	0.036	0.033	0	42.1	42.1	76.5	129	128	0	31	30
2015	7	26	7	26	52	0.2	-0.069	0.889	0.043	0.039	0	42.1	41.3	76.5	128	126	0	30	30
2015	7	26	7	36	52	0.148	-0.043	0.889	0.036	0.033	0	43.9	42.1	76.1	132	128	0	30	30
2015	7	26	7	46	52	0.138	0.003	0.889	0.036	0.033	0	41.3	41.7	77	127	127	0	31	30
2015	7	26	7	56	52	0.151	-0.02	0.889	0.036	0.033	0	41.7	41.7	77.8	128	126	0	31	29
2015	7	26	8	6	52	0.108	0.052	0.889	0.036	0.033	0	41.3	41.7	77	127	127	0	31	30
2015	7	26	8	16	52	0.22	0.016	0.889	0.039	0.036	0	44.7	44.3	74.4	135	133	0	31	30
2015	7	26	8	26	52	0.144	0.007	0.889	0.036	0.033	0	42.6	43	76.5	130	130	0	31	30
2015	7	26	8	36	52	0.2	0.066	0.892	0.036	0.033	0	43.4	43.9	75.7	132	132	0	31	30
2015	7	26	8	46	52	0.154	0.003	0.892	0.036	0.033	0	43	42.1	77	130	128	0	30	30
2015	7	26	8	56	52	0.177	0.052	0.892	0.033	0.03	0	43.9	44.3	76.1	133	133	0	31	30
2015	7	26	9	6	52	0.066	0.01	0.892	0.033	0.03	0	44.3	45.2	74	134	134	0	31	29
2015	7	26	9	16	52	0.125	0	0.892	0.036	0.033	0	43.9	43.9	75.3	133	132	0	31	30
2015	7	26	9	26	52	0.217	0.056	0.889	0.039	0.039	0	44.7	44.7	76.1	135	134	0	31	30
2015	7	26	9	36	52	0.171	0.01	0.892	0.036	0.033	0	46	44.7	75.7	137	134	0	30	30
2015	7	26	9	46	52	0.069	-0.039	0.892	0.036	0.033	0	45.6	45.2	75.7	136	135	0	30	30
2015	7	26	9	56	52	0.194	-0.056	0.889	0.033	0.03	0	47.7	46.9	73.1	142	139	0	31	30
2015	7	26	10	6	52	0.174	-0.03	0.892	0.033	0.03	0	45.6	46	74.8	136	137	0	30	30
2015	7	26	10	16	52	0.184	0.016	0.889	0.033	0.03	0	45.6	46.9	74.8	137	139	0	31	30
2015	7	26	10	26	52	0.217	0.01	0.889	0.036	0.033	0	47.3	47.3	74	140	139	0	30	29
2015	7	26	10	36	52	0.157	0.039	0.889	0.036	0.033	0	46.4	48.2	75.3	139	141	0	31	29
2015	7	26	10	46	52	0.135	-0.007	0.889	0.033	0.03	0	48.2	48.2	73.1	142	142	0	30	30
2015	7	26	10	56	52	0.184	0.043	0.889	0.036	0.033	0	46.9	48.6	73.5	140	143	0	31	30
2015	7	26	11	6	52	0.197	0.052	0.889	0.033	0.03	0	47.3	49	73.5	141	144	0	31	30
2015	7	26	11	16	52	0.194	0.072	0.889	0.036	0.033	0	47.3	49.5	73.5	140	144	0	30	29
2015	7	26	11	26	52	0.197	0.069	0.889	0.036	0.033	0	48.6	49.9	72.2	143	145	0	30	29
2015	7	26	11	36	52	0.22	0.016	0.889	0.036	0.033	0	48.6	50.3	72.2	144	146	0	31	29
2015	7	26	11	46	52	0.203	0.079	0.889	0.033	0.03	0	52	51.6	70.5	151	150	0	30	30
2015	7	26	11	56	52	0.223	0.033	0.889	0.036	0.033	0	50.3	51.6	69.7	147	150	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	26	12	6	52	0.194	-0.036	0.889	0.036	0.033	0	50.3	52	70.5	147	151	0	30	30
2015	7	26	12	16	52	0.187	0.052	0.886	0.036	0.033	0	51.2	52	70.5	150	150	0	31	29
2015	7	26	12	26	52	0.197	0.112	0.889	0.033	0.03	0	51.6	52.5	68.8	151	152	0	31	30
2015	7	26	12	36	52	0.157	0.039	0.886	0.033	0.03	0	51.6	52.9	69.7	150	153	0	30	30
2015	7	26	12	46	52	0.207	0.052	0.886	0.036	0.033	0	52.5	52.9	67.9	152	153	0	30	30
2015	7	26	12	56	52	0.207	0.056	0.886	0.033	0.03	0	52.5	52.5	67.5	152	152	0	30	30
2015	7	26	13	6	52	0.148	0	0.886	0.039	0.036	0	52	53.8	67.1	151	154	0	30	29
2015	7	26	13	16	52	0.2	0.066	0.886	0.033	0.033	0	52.5	53.3	67.1	152	153	0	30	29
2015	7	26	13	26	52	0.167	0.033	0.886	0.036	0.033	0	52.9	53.8	66.2	153	155	0	30	30
2015	7	26	13	36	52	0.171	0.01	0.889	0.033	0.03	0	53.3	53.3	67.5	154	154	0	30	30
2015	7	26	13	46	52	0.184	0.003	0.886	0.036	0.033	0	53.3	53.8	67.5	154	154	0	30	29
2015	7	26	13	56	52	0.161	0.026	0.886	0.036	0.033	0	54.6	54.2	67.1	157	156	0	30	30
2015	7	26	14	6	52	0.177	0.026	0.886	0.033	0.03	0	53.3	54.2	65.8	154	155	0	30	29
2015	7	26	14	16	52	0.161	0.059	0.886	0.033	0.03	0	52.9	54.6	66.2	153	156	0	30	29
2015	7	26	14	26	52	0.253	0.036	0.886	0.036	0.033	0	53.3	54.2	66.2	154	156	0	30	30
2015	7	26	14	36	52	0.138	0.026	0.886	0.033	0.03	0	53.8	54.2	66.2	155	155	0	30	29
2015	7	26	14	46	52	0.19	0.105	0.886	0.039	0.036	0	52.9	53.8	66.2	154	154	0	31	29
2015	7	26	14	56	52	0.203	0.062	0.886	0.036	0.033	0	54.2	54.2	64.9	156	155	0	30	29
2015	7	26	15	6	52	0.259	0.069	0.886	0.036	0.033	0	53.3	53.8	66.2	154	154	0	30	29
2015	7	26	15	16	52	0.21	0.112	0.886	0.033	0.03	0	54.6	54.6	64.9	157	156	0	30	29
2015	7	26	15	26	52	0.203	0.052	0.886	0.033	0.03	0	52.9	54.2	66.7	153	155	0	30	29
2015	7	26	15	36	52	0.128	0.039	0.883	0.033	0.03	0	52	54.6	67.1	151	156	0	30	29
2015	7	26	15	46	52	0.197	0.062	0.883	0.036	0.033	0	53.3	53.8	65.8	154	154	0	30	29
2015	7	26	15	56	52	0.256	0.049	0.886	0.033	0.03	0	52.5	52.9	65.8	152	152	0	30	29
2015	7	26	16	6	52	0.19	0.039	0.883	0.033	0.03	0	51.6	52.9	67.1	150	152	0	30	29
2015	7	26	16	16	52	0.213	0.046	0.883	0.03	0.03	0	52	52.9	67.1	151	152	0	30	29
2015	7	26	16	26	52	0.177	0.039	0.883	0.036	0.033	0	50.7	52	67.9	148	150	0	30	29
2015	7	26	16	36	52	0.151	0.075	0.883	0.033	0.03	0	50.3	51.2	67.9	147	149	0	30	30
2015	7	26	16	46	52	0.213	0.046	0.886	0.033	0.03	0	50.3	51.2	68.4	147	149	0	30	30
2015	7	26	16	56	52	0.226	0.062	0.883	0.033	0.03	0	49.9	50.3	67.9	146	146	0	30	29
2015	7	26	17	6	52	0.161	0.026	0.883	0.033	0.03	0	49.5	50.7	69.2	145	147	0	30	29
2015	7	26	17	16	52	0.22	0.036	0.883	0.033	0.03	0	48.6	49.5	69.7	143	145	0	30	30
2015	7	26	17	26	52	0.157	0.046	0.883	0.033	0.03	0	48.6	49	69.7	143	144	0	30	30
2015	7	26	17	36	52	0.174	-0.02	0.883	0.036	0.033	0	49	48.6	67.5	144	142	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	26	17	46	52	0.174	-0.007	0.883	0.033	0.03	0	47.7	47.7	68.8	141	140	0	30	29
2015	7	26	17	56	52	0.23	-0.007	0.883	0.036	0.033	0	47.3	46	69.7	140	136	0	30	29
2015	7	26	18	6	52	0.151	-0.039	0.883	0.036	0.033	0	47.3	45.6	69.7	139	135	0	29	29
2015	7	26	18	16	52	0.171	0.066	0.883	0.033	0.03	0	46.4	43.9	70.1	138	132	0	30	30
2015	7	26	18	26	52	0.151	0.013	0.883	0.039	0.036	0	46.9	44.3	69.7	139	132	0	30	29
2015	7	26	18	36	52	0.115	-0.003	0.883	0.039	0.036	0	46.4	44.3	69.7	138	133	0	30	30
2015	7	26	18	46	52	0.21	-0.033	0.883	0.043	0.039	0	47.7	46	69.2	141	136	0	30	29
2015	7	26	18	56	52	0.171	0.072	0.883	0.043	0.039	0	46.9	44.7	69.7	139	134	0	30	30
2015	7	26	19	6	52	0.19	-0.046	0.883	0.039	0.036	0	46.9	44.7	70.1	139	133	0	30	29
2015	7	26	19	16	52	0.177	-0.056	0.883	0.039	0.039	0	47.3	45.2	69.7	140	134	0	30	29
2015	7	26	19	26	52	0.23	-0.046	0.883	0.039	0.036	0	46.4	44.3	70.1	138	132	0	30	29
2015	7	26	19	36	52	0.164	0.023	0.883	0.043	0.039	0	46	44.7	70.1	137	133	0	30	29
2015	7	26	19	46	52	0.249	0	0.886	0.036	0.033	0	45.6	43.4	71.8	136	130	0	30	29
2015	7	26	19	56	52	0.167	-0.121	0.886	0.036	0.033	0	46.9	44.7	71	139	133	0	30	29
2015	7	26	20	6	52	0.164	0.023	0.886	0.033	0.03	0	47.3	45.2	70.1	140	134	0	30	29
2015	7	26	20	16	52	0.22	-0.007	0.886	0.039	0.039	0	46	43.9	71.8	137	132	0	30	30
2015	7	26	20	26	52	0.157	0.052	0.886	0.043	0.039	0	45.6	44.3	71.8	136	132	0	30	29
2015	7	26	20	36	52	0.19	-0.003	0.886	0.039	0.036	0	46.9	45.6	70.1	139	135	0	30	29
2015	7	26	20	46	52	0.151	0	0.886	0.039	0.039	0	47.3	45.6	69.7	140	135	0	30	29
2015	7	26	20	56	52	0.164	-0.036	0.886	0.039	0.039	0	45.6	44.7	71.4	136	132	0	30	28
2015	7	26	21	6	52	0.128	-0.01	0.886	0.036	0.033	0	45.2	43.9	72.2	135	131	0	30	29
2015	7	26	21	16	52	0.2	-0.039	0.886	0.036	0.033	0	45.2	43.4	72.7	135	129	0	30	28
2015	7	26	21	26	52	0.2	-0.016	0.886	0.036	0.033	0	45.6	43	72.7	135	129	0	29	29
2015	7	26	21	36	52	0.197	-0.046	0.886	0.036	0.033	0	46	44.3	71.8	136	132	0	29	29
2015	7	26	21	46	52	0.171	-0.026	0.886	0.039	0.036	0	46.9	45.6	71	139	135	0	30	29
2015	7	26	21	56	52	0.105	-0.036	0.886	0.043	0.039	0	45.2	43.4	72.2	135	129	0	30	28
2015	7	26	22	6	52	0.161	-0.003	0.889	0.039	0.036	0	46	45.2	72.2	137	134	0	30	29
2015	7	26	22	16	52	0.157	-0.036	0.886	0.033	0.03	0	43.9	42.1	73.1	132	128	0	30	30
2015	7	26	22	26	52	0.167	0.023	0.889	0.043	0.039	0	43.4	43	73.5	131	129	0	30	29
2015	7	26	22	36	52	0.164	0.007	0.886	0.039	0.039	0	44.3	43	73.5	133	129	0	30	29
2015	7	26	22	46	52	0.187	0.036	0.886	0.052	0.049	0	46	44.3	72.2	137	132	0	30	29
2015	7	26	22	56	52	0.207	-0.075	0.886	0.043	0.039	0	45.6	43.9	71.4	136	132	0	30	30
2015	7	26	23	6	52	0.2	-0.056	0.886	0.039	0.039	0	46	43.9	72.7	137	131	0	30	29
2015	7	26	23	16	52	0.19	-0.095	0.886	0.043	0.039	0	46.9	45.2	71	139	134	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	26	23	26	52	0.203	-0.066	0.886	0.039	0.039	0	45.6	44.7	71.8	136	133	0	30	29
2015	7	26	23	36	52	0.24	-0.049	0.886	0.036	0.033	0	46	44.3	72.2	137	132	0	30	29
2015	7	26	23	46	52	0.2	-0.072	0.886	0.039	0.039	0	46	44.3	72.7	137	132	0	30	29
2015	7	26	23	56	52	0.194	-0.056	0.886	0.039	0.036	0	45.2	43.9	72.2	135	132	0	30	30
2015	7	27	0	6	52	0.164	-0.062	0.886	0.039	0.039	0	45.2	43.9	72.2	135	131	0	30	29
2015	7	27	0	16	52	0.164	-0.069	0.886	0.039	0.036	0	46	44.7	72.7	137	133	0	30	29
2015	7	27	0	26	52	0.243	-0.023	0.886	0.043	0.039	0	44.7	43	72.2	135	130	0	31	30
2015	7	27	0	36	52	0.167	0.01	0.886	0.039	0.036	0	44.3	44.3	71.8	134	132	0	31	29
2015	7	27	0	46	52	0.187	-0.049	0.886	0.039	0.036	0	45.2	43.9	71.4	135	131	0	30	29
2015	7	27	0	56	52	0.243	-0.039	0.886	0.039	0.039	0	46.4	45.2	71.4	138	134	0	30	29
2015	7	27	1	6	52	0.217	0.003	0.886	0.039	0.039	0	49.9	48.2	67.9	146	142	0	30	30
2015	7	27	1	16	52	0.125	0.056	0.886	0.036	0.033	0	46.4	45.6	71.4	138	135	0	30	29
2015	7	27	1	26	52	0.157	-0.069	0.886	0.036	0.033	0	46.4	45.2	72.2	138	134	0	30	29
2015	7	27	1	36	52	0.171	0.016	0.886	0.039	0.036	0	45.6	43.4	72.2	136	131	0	30	30
2015	7	27	1	46	52	0.148	-0.105	0.886	0.043	0.039	0	45.2	44.3	72.7	135	132	0	30	29
2015	7	27	1	56	52	0.233	-0.033	0.886	0.039	0.039	0	45.6	44.7	72.2	136	133	0	30	29
2015	7	27	2	6	52	0.22	0.052	0.886	0.039	0.036	0	45.2	43.9	72.2	136	132	0	31	30
2015	7	27	2	16	52	0.154	-0.02	0.886	0.039	0.039	0	46	44.7	71.8	138	134	0	31	30
2015	7	27	2	26	52	0.138	-0.016	0.886	0.039	0.039	0	46.4	45.2	72.2	138	134	0	30	29
2015	7	27	2	36	52	0.144	-0.02	0.886	0.039	0.036	0	46.4	44.7	71.8	138	134	0	30	30
2015	7	27	2	46	52	0.167	0.069	0.886	0.043	0.039	0	48.2	46.9	69.2	143	138	0	31	29
2015	7	27	2	56	52	0.194	-0.049	0.886	0.036	0.033	0	46.4	45.2	71.8	139	135	0	31	30
2015	7	27	3	6	52	0.217	-0.039	0.886	0.039	0.036	0	46.4	45.6	70.1	139	136	0	31	30
2015	7	27	3	16	52	0.226	-0.043	0.886	0.039	0.039	0	47.7	47.3	68.8	142	139	0	31	29
2015	7	27	3	26	52	0.151	-0.039	0.886	0.039	0.039	0	47.7	46.9	69.2	141	138	0	30	29
2015	7	27	3	36	52	0.171	-0.043	0.886	0.043	0.039	0	46.9	45.2	69.7	139	135	0	30	30
2015	7	27	3	46	52	0.23	0	0.886	0.039	0.039	0	52	50.7	65.4	151	148	0	30	30
2015	7	27	3	56	52	0.148	0.049	0.886	0.039	0.036	0	47.3	46.9	69.7	141	138	0	31	29
2015	7	27	4	6	52	0.144	-0.033	0.886	0.039	0.039	0	46.9	45.6	71	140	136	0	31	30
2015	7	27	4	16	52	0.2	0	0.886	0.039	0.036	0	46	45.6	71.4	138	136	0	31	30
2015	7	27	4	26	52	0.174	0.085	0.886	0.033	0.03	0	48.2	47.3	68.4	143	140	0	31	30
2015	7	27	4	36	52	0.18	-0.013	0.886	0.039	0.036	0	46.4	45.6	71.4	139	135	0	31	29
2015	7	27	4	46	52	0.226	-0.043	0.886	0.039	0.036	0	46.4	44.3	71.8	138	133	0	30	30
2015	7	27	4	56	52	0.19	-0.02	0.886	0.039	0.036	0	49	47.3	68.4	145	140	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	27	5	6	52	0.184	-0.039	0.886	0.039	0.036	0	47.3	45.6	71	141	136	0	31	30
2015	7	27	5	16	52	0.164	0.016	0.886	0.039	0.036	0	46.9	45.6	71.4	140	136	0	31	30
2015	7	27	5	26	52	0.18	-0.033	0.886	0.039	0.039	0	46.9	45.2	71.8	139	135	0	30	30
2015	7	27	5	36	52	0.223	-0.108	0.886	0.039	0.036	0	47.7	46.4	69.7	142	138	0	31	30
2015	7	27	5	46	52	0.236	-0.059	0.886	0.033	0.03	0	47.7	46	71	141	137	0	30	30
2015	7	27	5	56	52	0.279	-0.052	0.886	0.049	0.049	0	46.9	45.6	71.4	139	136	0	30	30
2015	7	27	6	6	52	0.151	-0.069	0.886	0.039	0.039	0	52.9	52	64.9	154	151	0	31	30
2015	7	27	6	16	52	0.177	-0.003	0.886	0.039	0.039	0	47.3	45.6	71.8	140	136	0	30	30
2015	7	27	6	26	52	0.171	-0.075	0.886	0.039	0.036	0	53.3	51.6	62.8	154	150	0	30	30
2015	7	27	6	36	52	0.144	-0.036	0.883	0.036	0.033	0	49	48.6	64.9	145	143	0	31	30
2015	7	27	6	46	52	0.226	-0.036	0.886	0.039	0.039	0	55.5	54.6	58.5	160	157	0	31	30
2015	7	27	6	56	52	0.177	0.026	0.886	0.043	0.039	0	53.3	52	61.5	155	151	0	31	30
2015	7	27	7	6	52	0.115	-0.043	0.886	0.036	0.033	0	48.6	47.7	67.1	144	140	0	31	29
2015	7	27	7	16	52	0.167	-0.052	0.883	0.039	0.036	0	50.7	49.5	63.6	149	146	0	31	31
2015	7	27	7	26	52	0.161	-0.056	0.883	0.036	0.033	0	51.6	50.7	63.2	150	148	0	30	30
2015	7	27	7	36	52	0.23	0.039	0.886	0.036	0.033	0	52	51.2	63.6	151	149	0	30	30
2015	7	27	7	46	52	0.246	0.072	0.886	0.036	0.033	0	51.2	50.3	64.5	150	147	0	31	30
2015	7	27	7	56	52	0.148	0	0.886	0.036	0.033	0	50.3	49	65.8	147	144	0	30	30
2015	7	27	8	6	52	0.2	0.03	0.886	0.036	0.033	0	49.5	49	66.7	146	144	0	31	30
2015	7	27	8	16	52	0.118	0.036	0.883	0.039	0.036	0	50.3	49.5	65.4	148	145	0	31	30
2015	7	27	8	26	52	0.164	-0.01	0.886	0.039	0.039	0	50.3	49.9	65.8	148	146	0	31	30
2015	7	27	8	36	52	0.203	-0.033	0.886	0.049	0.046	0	51.2	49.9	67.1	149	146	0	30	30
2015	7	27	8	46	52	0.223	0.072	0.883	0.043	0.039	0	51.2	50.3	64.5	150	147	0	31	30
2015	7	27	8	56	52	0.22	0.036	0.883	0.039	0.036	0	50.7	49.5	64.1	148	145	0	30	30
2015	7	27	9	6	52	0.141	-0.003	0.883	0.039	0.036	0	51.2	49	66.2	149	144	0	30	30
2015	7	27	9	16	52	0.092	0.033	0.883	0.036	0.033	0	50.3	50.3	64.5	148	147	0	31	30
2015	7	27	9	26	52	0.128	0.052	0.883	0.036	0.033	0	50.7	49.5	66.7	149	145	0	31	30
2015	7	27	9	36	52	0.259	-0.108	0.883	0.033	0.03	0	49.9	49.5	68.8	147	144	0	31	29
2015	7	27	9	46	52	0.154	-0.043	0.883	0.033	0.03	0	49	49	69.7	145	144	0	31	30
2015	7	27	9	56	52	0.22	0.049	0.886	0.036	0.033	0	48.2	48.6	69.7	143	143	0	31	30
2015	7	27	10	6	52	0.151	0.079	0.883	0.033	0.03	0	48.6	49	68.4	144	144	0	31	30
2015	7	27	10	16	52	0.233	0.033	0.883	0.036	0.033	0	49.5	49	68.4	146	144	0	31	30
2015	7	27	10	26	52	0.19	0.046	0.883	0.033	0.03	0	49.5	49	69.2	146	144	0	31	30
2015	7	27	10	36	52	0.174	0.007	0.883	0.039	0.036	0	48.6	49.5	69.7	144	145	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	27	10	46	52	0.144	0.03	0.883	0.036	0.033	0	50.7	49	71	149	144	0	31	30
2015	7	27	10	56	52	0.207	-0.007	0.883	0.033	0.03	0	51.2	50.3	68.8	149	147	0	30	30
2015	7	27	11	6	52	0.19	0.03	0.883	0.033	0.03	0	50.3	50.3	70.1	148	147	0	31	30
2015	7	27	11	16	52	0.203	0.033	0.883	0.033	0.03	0	51.2	51.6	69.7	150	150	0	31	30
2015	7	27	11	26	52	0.131	0.043	0.883	0.033	0.03	0	51.2	51.6	69.7	150	150	0	31	30
2015	7	27	11	36	52	0.075	0.056	0.883	0.033	0.03	0	51.2	51.2	68.8	150	149	0	31	30
2015	7	27	11	46	52	0.141	0.062	0.883	0.036	0.033	0	51.6	52	68.4	150	151	0	30	30
2015	7	27	11	56	52	0.167	0.033	0.879	0.033	0.03	0	52.5	52.9	66.7	152	153	0	30	30
2015	7	27	12	6	52	0.157	0.079	0.879	0.033	0.03	0	53.3	52.5	65.8	155	152	0	31	30
2015	7	27	12	16	52	0.2	0.01	0.879	0.033	0.03	0	53.8	53.8	68.8	156	154	0	31	29
2015	7	27	12	26	52	0.164	0.007	0.879	0.036	0.033	0	53.3	53.8	65.8	155	155	0	31	30
2015	7	27	12	36	52	0.161	0.056	0.879	0.039	0.036	0	53.8	54.2	67.5	156	156	0	31	30
2015	7	27	12	46	52	0.174	0.118	0.879	0.036	0.033	0	54.6	54.2	65.8	157	156	0	30	30
2015	7	27	12	56	52	0.125	0.046	0.876	0.033	0.03	0	53.8	55	65.4	156	157	0	31	29
2015	7	27	13	6	52	0.18	0.092	0.876	0.033	0.03	0	54.2	54.6	65.8	157	157	0	31	30
2015	7	27	13	16	52	0.144	0.003	0.876	0.036	0.033	0	54.6	55.5	66.7	158	159	0	31	30
2015	7	27	13	26	52	0.141	0.112	0.876	0.033	0.03	0	54.6	55.9	65.4	157	160	0	30	30
2015	7	27	13	36	52	0.105	0.056	0.873	0.036	0.033	0	54.6	55.5	64.1	157	159	0	30	30
2015	7	27	13	46	52	0.213	0.062	0.873	0.036	0.033	0	54.6	55.5	64.9	158	158	0	31	29
2015	7	27	13	56	52	0.141	0.052	0.873	0.033	0.03	0	54.2	55.9	65.4	157	159	0	31	29
2015	7	27	14	6	52	0.148	0.056	0.873	0.033	0.033	0	55	55.9	65.4	159	160	0	31	30
2015	7	27	14	16	52	0.112	0.023	0.869	0.033	0.03	0	55.5	56.3	64.5	159	160	0	30	29
2015	7	27	14	26	52	0.092	0.043	0.873	0.039	0.036	0	55.5	56.3	64.9	159	160	0	30	29
2015	7	27	14	36	52	0.095	0.062	0.869	0.033	0.03	0	54.2	56.3	65.4	157	160	0	31	29
2015	7	27	14	46	52	0.174	-0.036	0.869	0.036	0.033	0	55.9	55.9	64.5	160	160	0	30	30
2015	7	27	14	56	52	0.167	0.098	0.869	0.039	0.039	0	56.3	55.9	63.2	161	160	0	30	30
2015	7	27	15	6	52	0.125	0.007	0.869	0.036	0.033	0	56.8	57.2	63.2	162	162	0	30	29
2015	7	27	15	16	52	0.148	0.03	0.869	0.036	0.033	0	55.9	55.9	64.9	160	160	0	30	30
2015	7	27	15	26	52	0.148	0.059	0.869	0.039	0.036	0	56.8	56.8	62.4	162	161	0	30	29
2015	7	27	15	36	52	0.115	0.075	0.869	0.036	0.033	0	55.9	56.3	64.9	160	160	0	30	29
2015	7	27	15	46	52	0.138	0.056	0.866	0.033	0.03	0	56.3	56.8	64.1	161	161	0	30	29
2015	7	27	15	56	52	0.164	0.036	0.866	0.036	0.033	0	55.5	55.5	65.4	159	158	0	30	29
2015	7	27	16	6	52	0.167	0.056	0.866	0.039	0.036	0	58	56.8	63.2	164	161	0	29	29
2015	7	27	16	16	52	0.184	0.059	0.866	0.036	0.033	0	56.3	55.9	63.6	161	159	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	27	16	26	52	0.187	0.075	0.866	0.039	0.036	0	57.6	56.8	61.9	164	161	0	30	29
2015	7	27	16	36	52	0.177	0.016	0.866	0.036	0.033	0	56.3	55.5	63.6	162	159	0	31	30
2015	7	27	16	46	52	0.184	-0.003	0.866	0.033	0.03	0	55.5	55.5	64.1	159	158	0	30	29
2015	7	27	16	56	52	0.217	0.033	0.866	0.033	0.03	0	55	54.6	65.4	158	156	0	30	29
2015	7	27	17	6	52	0.154	0.01	0.866	0.039	0.036	0	54.2	54.2	65.8	156	155	0	30	29
2015	7	27	17	16	52	0.269	0.049	0.866	0.033	0.033	0	53.8	52.9	67.1	155	152	0	30	29
2015	7	27	17	26	52	0.157	-0.036	0.866	0.036	0.033	0	51.2	51.6	67.9	149	149	0	30	29
2015	7	27	17	36	52	0.246	0.056	0.866	0.036	0.033	0	49.5	49	70.1	145	144	0	30	30
2015	7	27	17	46	52	0.167	0.098	0.866	0.036	0.033	0	47.3	48.6	69.7	141	142	0	31	29
2015	7	27	17	56	52	0.072	0.033	0.866	0.039	0.039	0	52.5	51.2	67.1	152	149	0	30	30
2015	7	27	18	6	52	0.138	-0.105	0.866	0.039	0.036	0	50.7	49.5	68.8	148	144	0	30	29
2015	7	27	18	16	52	0.213	-0.062	0.866	0.039	0.039	0	52	50.3	67.1	151	146	0	30	29
2015	7	27	18	26	52	0.226	0.049	0.866	0.036	0.033	0	49.5	48.2	69.2	145	141	0	30	29
2015	7	27	18	36	52	0.187	0.007	0.866	0.039	0.039	0	51.2	49.5	68.4	149	144	0	30	29
2015	7	27	18	46	52	0.171	-0.059	0.866	0.039	0.036	0	52	49.9	66.7	151	146	0	30	30
2015	7	27	18	56	52	0.171	-0.016	0.866	0.039	0.039	0	50.7	48.2	68.8	148	142	0	30	30
2015	7	27	19	6	52	0.187	-0.082	0.866	0.039	0.036	0	51.6	49.9	67.9	150	145	0	30	29
2015	7	27	19	16	52	0.161	-0.026	0.866	0.043	0.039	0	50.7	48.6	67.5	148	142	0	30	29
2015	7	27	19	26	52	0.148	-0.052	0.869	0.039	0.036	0	49	46.9	69.2	144	138	0	30	29
2015	7	27	19	36	52	0.112	-0.039	0.869	0.049	0.046	0	49	46.9	69.2	144	138	0	30	29
2015	7	27	19	46	52	0.19	0	0.869	0.043	0.039	0	48.2	46.4	70.5	142	137	0	30	29
2015	7	27	19	56	52	0.233	-0.02	0.869	0.039	0.039	0	49.9	48.2	69.2	146	141	0	30	29
2015	7	27	20	6	52	0.243	-0.036	0.869	0.036	0.033	0	48.2	45.6	71	142	135	0	30	29
2015	7	27	20	16	52	0.226	0.013	0.869	0.036	0.033	0	47.7	45.2	71.4	141	135	0	30	30
2015	7	27	20	26	52	0.121	-0.003	0.866	0.036	0.033	0	52	49.5	67.9	151	144	0	30	29
2015	7	27	20	36	52	0.18	0.03	0.866	0.036	0.033	0	48.6	46.4	71	143	137	0	30	29
2015	7	27	20	46	52	0.233	-0.003	0.866	0.039	0.039	0	46.9	45.2	70.5	139	135	0	30	30
2015	7	27	20	56	52	0.141	-0.036	0.866	0.036	0.033	0	47.3	45.2	71.8	140	135	0	30	30
2015	7	27	21	6	52	0.157	-0.046	0.866	0.036	0.033	0	45.6	44.3	72.7	136	132	0	30	29
2015	7	27	21	16	52	0.203	-0.023	0.866	0.039	0.039	0	46.4	44.3	72.2	138	132	0	30	29
2015	7	27	21	26	52	0.154	-0.066	0.866	0.039	0.036	0	46.9	44.7	71.8	139	134	0	30	30
2015	7	27	21	36	52	0.187	-0.039	0.866	0.036	0.033	0	46	44.3	72.7	137	132	0	30	29
2015	7	27	21	46	52	0.167	0.01	0.866	0.043	0.039	0	46.9	44.7	71.8	139	134	0	30	30
2015	7	27	21	56	52	0.151	0.003	0.866	0.039	0.039	0	46.9	45.2	71	139	134	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	27	22	6	52	0.197	0.03	0.866	0.039	0.036	0	45.6	43.9	72.7	136	131	0	30	29
2015	7	27	22	16	52	0.187	0.013	0.866	0.036	0.033	0	45.2	42.6	73.1	135	130	0	30	31
2015	7	27	22	26	52	0.171	-0.056	0.866	0.039	0.036	0	46	44.7	71.4	137	133	0	30	29
2015	7	27	22	36	52	0.243	0	0.866	0.046	0.043	0	47.7	46.4	71	141	136	0	30	28
2015	7	27	22	46	52	0.157	-0.062	0.866	0.039	0.039	0	49	47.7	70.1	144	140	0	30	29
2015	7	27	22	56	52	0.141	-0.007	0.866	0.039	0.039	0	48.6	47.3	69.7	143	139	0	30	29
2015	7	27	23	6	52	0.167	-0.072	0.866	0.036	0.033	0	46.4	44.7	71.8	138	133	0	30	29
2015	7	27	23	16	52	0.131	-0.056	0.866	0.039	0.036	0	45.6	44.3	71.8	137	133	0	31	30
2015	7	27	23	26	52	0.135	-0.03	0.866	0.039	0.036	0	46.4	44.7	71.4	138	134	0	30	30
2015	7	27	23	36	52	0.151	-0.023	0.866	0.036	0.033	0	46.9	44.7	71	139	133	0	30	29
2015	7	27	23	46	52	0.249	-0.016	0.866	0.039	0.036	0	46	45.2	71.8	137	134	0	30	29
2015	7	27	23	56	52	0.128	-0.036	0.863	0.033	0.03	0	51.2	49.9	66.2	150	146	0	31	30
2015	7	28	0	6	52	0.115	-0.059	0.866	0.033	0.03	0	46.4	44.7	71	138	134	0	30	30
2015	7	28	0	16	52	0.226	0.026	0.866	0.039	0.039	0	45.6	44.7	71.4	137	134	0	31	30
2015	7	28	0	26	52	0.157	-0.023	0.866	0.039	0.036	0	46.4	44.7	71	138	134	0	30	30
2015	7	28	0	36	52	0.138	-0.01	0.866	0.036	0.033	0	46	44.3	71.4	137	132	0	30	29
2015	7	28	0	46	52	0.138	0.056	0.866	0.039	0.036	0	45.6	44.7	71	136	133	0	30	29
2015	7	28	0	56	52	0.121	0.016	0.866	0.039	0.039	0	44.3	44.3	71.8	134	132	0	31	29
2015	7	28	1	6	52	0.131	0.016	0.866	0.033	0.03	0	45.2	44.3	71.8	135	132	0	30	29
2015	7	28	1	16	52	0.19	-0.079	0.863	0.043	0.043	0	46.9	44.7	71	139	134	0	30	30
2015	7	28	1	26	52	0.105	-0.062	0.866	0.039	0.039	0	44.7	43.9	72.7	135	131	0	31	29
2015	7	28	1	36	52	0.157	0.016	0.866	0.039	0.036	0	43.4	43.9	72.2	132	131	0	31	29
2015	7	28	1	46	52	0.187	-0.02	0.866	0.036	0.033	0	45.2	43.9	71.4	136	132	0	31	30
2015	7	28	1	56	52	0.207	-0.02	0.866	0.036	0.033	0	44.7	43.9	71.8	135	131	0	31	29
2015	7	28	2	6	52	0.184	-0.026	0.866	0.043	0.039	0	45.6	45.2	71	137	134	0	31	29
2015	7	28	2	16	52	0.059	-0.01	0.866	0.043	0.039	0	43.9	43	71.4	133	130	0	31	30
2015	7	28	2	26	52	0.177	-0.033	0.866	0.039	0.036	0	43.9	43.9	72.2	132	131	0	30	29
2015	7	28	2	36	52	0.138	-0.026	0.866	0.033	0.033	0	45.6	44.7	71	136	134	0	30	30
2015	7	28	2	46	52	0.108	-0.003	0.866	0.039	0.036	0	43.9	44.3	72.2	132	132	0	30	29
2015	7	28	2	56	52	0.157	-0.062	0.866	0.039	0.036	0	45.2	43.9	71	136	132	0	31	30
2015	7	28	3	6	52	0.184	0	0.866	0.039	0.039	0	44.7	43.9	71	135	132	0	31	30
2015	7	28	3	16	52	0.164	-0.01	0.866	0.036	0.033	0	46.4	45.2	68.8	139	135	0	31	30
2015	7	28	3	26	52	0.138	0.043	0.866	0.039	0.036	0	48.2	46.9	67.1	142	139	0	30	30
2015	7	28	3	36	52	0.125	0.01	0.869	0.033	0.03	0	46.4	45.2	68.8	139	135	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	28	3	46	52	0.174	0	0.866	0.036	0.033	0	46	46	68.4	138	136	0	31	29
2015	7	28	3	56	52	0.23	0.052	0.866	0.039	0.036	0	46	45.2	67.9	138	135	0	31	30
2015	7	28	4	6	52	0.177	-0.059	0.869	0.036	0.033	0	47.7	46	67.5	141	136	0	30	29
2015	7	28	4	16	52	0.164	-0.039	0.866	0.039	0.036	0	49	47.7	65.8	144	140	0	30	29
2015	7	28	4	26	52	0.164	-0.056	0.869	0.039	0.036	0	48.6	47.3	67.1	143	140	0	30	30
2015	7	28	4	36	52	0.213	-0.079	0.869	0.039	0.036	0	46.9	46.4	66.2	140	138	0	31	30
2015	7	28	4	46	52	0.23	0.039	0.869	0.036	0.033	0	46.4	45.6	66.7	139	136	0	31	30
2015	7	28	4	56	52	0.121	0.036	0.873	0.036	0.033	0	47.7	45.6	68.4	141	137	0	30	31
2015	7	28	5	6	52	0.121	-0.01	0.873	0.036	0.033	0	46.4	46	65.8	139	137	0	31	30
2015	7	28	5	16	52	0.141	0.013	0.873	0.033	0.03	0	46.9	45.6	67.1	140	136	0	31	30
2015	7	28	5	26	52	0.144	-0.02	0.873	0.039	0.036	0	48.6	46.9	66.2	143	139	0	30	30
2015	7	28	5	36	52	0.115	0.003	0.873	0.039	0.036	0	48.2	47.3	65.4	143	139	0	31	29
2015	7	28	5	46	52	0.184	-0.072	0.876	0.033	0.03	0	49.5	47.7	64.9	146	141	0	31	30
2015	7	28	5	56	52	0.262	-0.007	0.876	0.036	0.033	0	46.4	45.6	67.9	139	136	0	31	30
2015	7	28	6	6	52	0.253	0	0.876	0.039	0.036	0	46	43.9	67.1	137	133	0	30	31
2015	7	28	6	16	52	0.279	0.016	0.876	0.039	0.036	0	45.2	44.7	70.1	136	134	0	31	30
2015	7	28	6	26	52	0.135	-0.013	0.879	0.036	0.033	0	45.2	44.3	68.8	135	133	0	30	30
2015	7	28	6	36	52	0.197	0.016	0.879	0.039	0.036	0	45.2	43.9	69.7	135	132	0	30	30
2015	7	28	6	46	52	0.157	0.013	0.879	0.036	0.033	0	43.9	43.4	70.5	133	131	0	31	30
2015	7	28	6	56	52	0.21	-0.033	0.879	0.036	0.033	0	43.4	43.4	71	132	131	0	31	30
2015	7	28	7	6	52	0.141	0.059	0.879	0.039	0.036	0	43.4	44.3	71.8	132	133	0	31	30
2015	7	28	7	16	52	0.161	-0.013	0.879	0.033	0.03	0	43.9	43.4	71	133	131	0	31	30
2015	7	28	7	26	52	0.174	0	0.879	0.036	0.033	0	43	43.9	70.1	131	132	0	31	30
2015	7	28	7	36	52	0.072	-0.02	0.879	0.039	0.036	0	43.9	43.9	71	133	132	0	31	30
2015	7	28	7	46	52	0.157	0	0.879	0.039	0.036	0	44.3	44.3	71.4	133	133	0	30	30
2015	7	28	7	56	52	0.148	-0.039	0.879	0.033	0.03	0	44.3	44.3	71.4	135	133	0	32	30
2015	7	28	8	6	52	0.177	-0.007	0.879	0.033	0.033	0	43.9	45.2	70.1	134	135	0	32	30
2015	7	28	8	16	52	0.157	0.01	0.879	0.036	0.033	0	44.7	45.2	70.1	135	135	0	31	30
2015	7	28	8	26	52	0.154	0.003	0.879	0.043	0.039	0	45.2	44.3	70.1	136	133	0	31	30
2015	7	28	8	36	52	0.148	0.052	0.879	0.033	0.03	0	45.6	45.2	70.1	137	135	0	31	30
2015	7	28	8	46	52	0.161	0.023	0.876	0.039	0.036	0	46	45.6	67.1	138	136	0	31	30
2015	7	28	8	56	52	0.22	-0.02	0.879	0.036	0.033	0	47.3	46.4	68.8	140	138	0	30	30
2015	7	28	9	6	52	0.154	0.003	0.879	0.036	0.033	0	47.3	46.4	68.8	141	138	0	31	30
2015	7	28	9	16	52	0.141	0	0.879	0.033	0.03	0	46.4	46.9	68.8	138	139	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	28	9	26	52	0.187	-0.039	0.879	0.033	0.03	0	47.3	46.4	69.7	141	138	0	31	30
2015	7	28	9	36	52	0.18	0.069	0.879	0.036	0.033	0	47.7	47.3	68.8	142	140	0	31	30
2015	7	28	9	46	52	0.18	0.056	0.879	0.033	0.03	0	47.7	48.2	68.8	143	142	0	32	30
2015	7	28	9	56	52	0.141	-0.003	0.879	0.036	0.033	0	47.7	47.7	70.5	142	141	0	31	30
2015	7	28	10	6	52	0.154	0.033	0.879	0.036	0.033	0	47.3	47.7	69.7	141	141	0	31	30
2015	7	28	10	16	52	0.125	-0.02	0.879	0.033	0.03	0	47.7	47.3	71	142	140	0	31	30
2015	7	28	10	26	52	0.226	-0.033	0.879	0.033	0.03	0	47.7	47.7	70.5	142	141	0	31	30
2015	7	28	10	36	52	0.194	0.066	0.879	0.036	0.033	0	48.6	47.7	71.4	144	141	0	31	30
2015	7	28	10	46	52	0.164	0.033	0.879	0.036	0.033	0	47.7	47.7	70.1	142	141	0	31	30
2015	7	28	10	56	52	0.19	0.023	0.879	0.036	0.033	0	48.2	49	71.4	143	144	0	31	30
2015	7	28	11	6	52	0.125	0.052	0.879	0.033	0.03	0	48.6	49.9	70.5	144	146	0	31	30
2015	7	28	11	16	52	0.164	-0.03	0.879	0.036	0.033	0	49	49.9	71	144	146	0	30	30
2015	7	28	11	26	52	0.226	0.033	0.879	0.043	0.039	0	49.9	51.6	69.2	147	150	0	31	30
2015	7	28	11	36	52	0.151	0	0.879	0.036	0.033	0	50.3	51.6	68.8	148	150	0	31	30
2015	7	28	11	46	52	0.174	0.056	0.876	0.036	0.033	0	49.9	52	68.8	146	151	0	30	30
2015	7	28	11	56	52	0.098	0.01	0.876	0.033	0.03	0	50.7	52	69.2	149	151	0	31	30
2015	7	28	12	6	52	0.18	0.043	0.876	0.039	0.036	0	51.2	52.5	69.2	150	152	0	31	30
2015	7	28	12	16	52	0.18	0.046	0.876	0.036	0.033	0	52	52.9	66.7	151	153	0	30	30
2015	7	28	12	26	52	0.171	0.016	0.873	0.033	0.03	0	51.6	52.9	67.5	151	153	0	31	30
2015	7	28	12	36	52	0.151	-0.023	0.876	0.033	0.03	0	52.5	53.3	67.9	153	154	0	31	30
2015	7	28	12	46	52	0.177	0.075	0.876	0.036	0.033	0	53.8	53.8	67.5	156	155	0	31	30
2015	7	28	12	56	52	0.177	0.066	0.873	0.033	0.03	0	53.3	53.8	66.7	155	155	0	31	30
2015	7	28	13	6	52	0.144	0.092	0.876	0.036	0.033	0	54.2	54.6	66.2	156	157	0	30	30
2015	7	28	13	16	52	0.151	0.131	0.876	0.036	0.033	0	53.8	54.2	67.1	156	156	0	31	30
2015	7	28	13	26	52	0.174	0.007	0.873	0.033	0.03	0	53.8	54.6	67.1	155	156	0	30	29
2015	7	28	13	36	52	0.246	0.046	0.873	0.033	0.03	0	54.6	54.2	67.1	157	156	0	30	30
2015	7	28	13	46	52	0.203	-0.003	0.873	0.033	0.03	0	54.6	55.5	65.4	157	158	0	30	29
2015	7	28	13	56	52	0.19	0.072	0.869	0.036	0.033	0	55	55	65.4	158	158	0	30	30
2015	7	28	14	6	52	0.151	0.033	0.869	0.036	0.033	0	55.5	55	64.1	159	158	0	30	30
2015	7	28	14	16	52	0.187	0.121	0.869	0.033	0.03	0	55	55	64.9	158	157	0	30	29
2015	7	28	14	26	52	0.256	0.161	0.873	0.039	0.036	0	55.5	55	64.9	159	158	0	30	30
2015	7	28	14	36	52	0.223	0.128	0.869	0.033	0.03	0	55.5	55.5	65.8	159	159	0	30	30
2015	7	28	14	46	52	0.223	0.059	0.869	0.033	0.03	0	54.6	54.6	65.8	157	156	0	30	29
2015	7	28	14	56	52	0.24	0.003	0.869	0.033	0.03	0	54.6	55.5	65.4	157	158	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	28	15	6	52	0.161	0.016	0.869	0.033	0.03	0	55.5	55.5	66.7	159	158	0	30	29
2015	7	28	15	16	52	0.246	0.108	0.869	0.033	0.03	0	55.5	55	66.7	159	157	0	30	29
2015	7	28	15	26	52	0.167	0.049	0.869	0.036	0.033	0	55.9	55	67.1	159	158	0	29	30
2015	7	28	15	36	52	0.213	0.062	0.869	0.033	0.03	0	55	53.8	66.7	159	155	0	31	30
2015	7	28	15	46	52	0.105	0.082	0.869	0.039	0.039	0	55.9	55	64.5	160	158	0	30	30
2015	7	28	15	56	52	0.154	0.072	0.869	0.033	0.03	0	54.6	53.8	67.1	157	154	0	30	29
2015	7	28	16	6	52	0.177	0.089	0.866	0.039	0.036	0	54.6	55	65.4	157	157	0	30	29
2015	7	28	16	16	52	0.171	0.072	0.866	0.036	0.033	0	55	54.6	65.8	158	156	0	30	29
2015	7	28	16	26	52	0.144	0.089	0.869	0.033	0.03	0	54.2	53.8	65.8	156	154	0	30	29
2015	7	28	16	36	52	0.23	0.03	0.866	0.033	0.03	0	53.8	52.9	67.5	155	153	0	30	30
2015	7	28	16	46	52	0.148	0.095	0.869	0.036	0.033	0	53.3	52.9	66.7	154	152	0	30	29
2015	7	28	16	56	52	0.262	0.003	0.869	0.036	0.033	0	52.5	52	68.8	152	150	0	30	29
2015	7	28	17	6	52	0.19	0.079	0.869	0.039	0.036	0	52	51.6	69.2	151	149	0	30	29
2015	7	28	17	16	52	0.207	0.066	0.869	0.039	0.036	0	50.7	50.3	69.7	148	146	0	30	29
2015	7	28	17	26	52	0.194	0.016	0.866	0.036	0.033	0	51.6	50.7	69.7	150	147	0	30	29
2015	7	28	17	36	52	0.167	-0.016	0.869	0.043	0.039	0	49.5	48.2	70.5	145	142	0	30	30
2015	7	28	17	46	52	0.154	0.112	0.869	0.036	0.033	0	48.2	47.7	71.8	142	140	0	30	29
2015	7	28	17	56	52	0.187	-0.03	0.869	0.039	0.036	0	46.9	46	72.2	139	136	0	30	29
2015	7	28	18	6	52	0.19	0.023	0.869	0.033	0.03	0	46	45.2	73.5	137	134	0	30	29
2015	7	28	18	16	52	0.131	0.03	0.869	0.039	0.036	0	46	44.7	72.7	138	134	0	31	30
2015	7	28	18	26	52	0.157	0.079	0.869	0.036	0.033	0	46.4	44.3	72.7	138	133	0	30	30
2015	7	28	18	36	52	0.197	0.039	0.869	0.039	0.036	0	45.6	44.7	73.5	137	133	0	31	29
2015	7	28	18	46	52	0.128	0.016	0.866	0.039	0.039	0	48.6	46.4	70.5	143	137	0	30	29
2015	7	28	18	56	52	0.144	0.01	0.866	0.039	0.036	0	53.8	51.6	65.8	156	149	0	31	29
2015	7	28	19	6	52	0.266	0	0.866	0.046	0.043	0	52	49.9	67.9	151	145	0	30	29
2015	7	28	19	16	52	0.174	-0.02	0.866	0.039	0.039	0	53.8	52.5	65.4	156	150	0	31	28
2015	7	28	19	26	52	0.164	-0.039	0.866	0.039	0.039	0	53.8	51.2	65.8	155	148	0	30	29
2015	7	28	19	36	52	0.138	0.016	0.866	0.039	0.039	0	55.9	53.8	62.8	160	154	0	30	29
2015	7	28	19	46	52	0.144	-0.003	0.866	0.039	0.036	0	57.2	54.2	60.6	163	156	0	30	30
2015	7	28	19	56	52	0.187	-0.01	0.869	0.043	0.039	0	57.2	55	61.1	163	157	0	30	29
2015	7	28	20	6	52	0.266	-0.02	0.869	0.039	0.036	0	56.8	54.2	61.9	162	155	0	30	29
2015	7	28	20	16	52	0.236	-0.062	0.869	0.039	0.039	0	56.8	54.2	61.9	162	155	0	30	29
2015	7	28	20	26	52	0.164	-0.036	0.869	0.039	0.036	0	55.5	53.3	62.4	159	153	0	30	29
2015	7	28	20	36	52	0.243	-0.056	0.869	0.039	0.036	0	55	52	62.4	158	151	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	28	20	46	52	0.285	-0.039	0.869	0.043	0.039	0	54.6	51.6	63.2	157	150	0	30	30
2015	7	28	20	56	52	0.144	-0.075	0.869	0.039	0.036	0	55	52.9	61.9	158	152	0	30	29
2015	7	28	21	6	52	0.171	0.01	0.869	0.046	0.043	0	54.6	52	63.2	157	151	0	30	30
2015	7	28	21	16	52	0.141	-0.046	0.869	0.039	0.039	0	53.8	50.7	64.1	155	148	0	30	30
2015	7	28	21	26	52	0.161	0.049	0.869	0.039	0.036	0	51.2	48.6	66.2	149	143	0	30	30
2015	7	28	21	36	52	0.148	0.016	0.873	0.046	0.043	0	49	46.9	68.4	144	138	0	30	29
2015	7	28	21	46	52	0.066	-0.033	0.873	0.036	0.033	0	47.3	45.2	70.1	140	134	0	30	29
2015	7	28	21	56	52	0.194	-0.056	0.869	0.039	0.036	0	47.3	45.2	69.2	140	135	0	30	30
2015	7	28	22	6	52	0.203	-0.062	0.873	0.036	0.033	0	46.9	45.6	69.7	139	135	0	30	29
2015	7	28	22	16	52	0.174	0.007	0.873	0.036	0.033	0	45.2	43.9	71	135	131	0	30	29
2015	7	28	22	26	52	0.171	-0.105	0.873	0.043	0.039	0	45.2	44.3	71	135	132	0	30	29
2015	7	28	22	36	52	0.197	0.007	0.869	0.039	0.036	0	47.7	46	69.2	141	136	0	30	29
2015	7	28	22	46	52	0.167	-0.01	0.873	0.039	0.039	0	46.9	45.6	69.7	139	135	0	30	29
2015	7	28	22	56	52	0.128	0.095	0.873	0.039	0.036	0	47.3	45.6	69.2	140	136	0	30	30
2015	7	28	23	6	52	0.102	0.023	0.873	0.036	0.033	0	46.9	46.4	68.4	140	137	0	31	29
2015	7	28	23	16	52	0.128	0.036	0.876	0.039	0.039	0	46	44.3	71	137	133	0	30	30
2015	7	28	23	26	52	0.141	0.092	0.876	0.039	0.036	0	45.6	43.9	71	136	132	0	30	30
2015	7	28	23	36	52	0.148	0	0.876	0.039	0.039	0	43.9	43	71.4	133	130	0	31	30
2015	7	28	23	46	52	0.108	0.036	0.879	0.036	0.033	0	43.9	43.4	71.4	133	130	0	31	29
2015	7	28	23	56	52	0.141	-0.013	0.876	0.039	0.036	0	46.4	44.7	70.1	138	134	0	30	30
2015	7	29	0	6	52	0.105	0.177	0.876	0.049	0.049	0	45.2	44.7	71	135	133	0	30	29
2015	7	29	0	16	52	0.128	-0.013	0.876	0.036	0.033	0	44.3	43.9	71.4	133	131	0	30	29
2015	7	29	0	26	52	0.118	-0.03	0.876	0.039	0.039	0	47.3	46	69.7	140	136	0	30	29
2015	7	29	0	36	52	0.164	-0.046	0.876	0.039	0.036	0	44.3	44.3	71.4	134	132	0	31	29
2015	7	29	0	46	52	0.092	0.003	0.879	0.036	0.033	0	43.4	43.9	71.8	131	131	0	30	29
2015	7	29	0	56	52	0.19	0	0.879	0.036	0.033	0	43.9	43.9	72.7	133	132	0	31	30
2015	7	29	1	6	52	0.285	-0.007	0.879	0.033	0.03	0	43.4	43	72.2	131	130	0	30	30
2015	7	29	1	16	52	0.194	0.01	0.876	0.039	0.039	0	44.3	43.9	71.8	134	132	0	31	30
2015	7	29	1	26	52	0.226	0.01	0.879	0.036	0.033	0	43.9	43.4	71.8	132	131	0	30	30
2015	7	29	1	36	52	0.144	0.056	0.879	0.039	0.036	0	43	43.9	72.7	131	131	0	31	29
2015	7	29	1	46	52	0.174	0.023	0.879	0.036	0.033	0	43	43.4	72.2	131	131	0	31	30
2015	7	29	1	56	52	0.148	0.052	0.876	0.039	0.039	0	46.4	45.2	70.5	138	135	0	30	30
2015	7	29	2	6	52	0.233	0.075	0.876	0.039	0.036	0	46	45.2	70.1	137	134	0	30	29
2015	7	29	2	16	52	0.161	-0.013	0.876	0.043	0.039	0	45.2	44.3	71.4	135	133	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	29	2	26	52	0.164	0.023	0.879	0.039	0.036	0	45.2	44.3	71	135	133	0	30	30
2015	7	29	2	36	52	0.056	0.023	0.879	0.033	0.03	0	43.9	43.9	71.4	133	132	0	31	30
2015	7	29	2	46	52	0.151	-0.036	0.879	0.036	0.033	0	44.7	44.3	71	134	132	0	30	29
2015	7	29	2	56	52	0.112	-0.135	0.876	0.039	0.036	0	44.3	44.3	71	134	132	0	31	29
2015	7	29	3	6	52	0.187	0.003	0.876	0.039	0.039	0	46.4	45.2	69.2	139	135	0	31	30
2015	7	29	3	16	52	0.157	-0.03	0.876	0.039	0.039	0	47.7	46.4	68.4	141	138	0	30	30
2015	7	29	3	26	52	0.154	0.003	0.876	0.039	0.036	0	44.7	43.4	71.4	135	131	0	31	30
2015	7	29	3	36	52	0.167	0.023	0.879	0.039	0.036	0	43.4	43	71.4	132	130	0	31	30
2015	7	29	3	46	52	0.095	0.03	0.879	0.033	0.03	0	44.3	44.3	71.4	133	133	0	30	30
2015	7	29	3	56	52	0.157	-0.075	0.876	0.033	0.03	0	44.7	43.4	72.2	134	131	0	30	30
2015	7	29	4	6	52	0.118	0.013	0.879	0.036	0.033	0	44.7	43.9	71.4	134	132	0	30	30
2015	7	29	4	16	52	0.157	-0.039	0.876	0.039	0.039	0	44.3	44.7	71	134	133	0	31	29
2015	7	29	4	26	52	0.174	-0.03	0.876	0.039	0.036	0	43.9	43.4	71.4	133	131	0	31	30
2015	7	29	4	36	52	0.095	-0.075	0.876	0.039	0.036	0	44.7	44.3	71	134	133	0	30	30
2015	7	29	4	46	52	0.141	0	0.876	0.046	0.043	0	48.2	47.3	67.5	143	140	0	31	30
2015	7	29	4	56	52	0.141	-0.003	0.876	0.036	0.033	0	46.4	44.3	70.5	138	134	0	30	31
2015	7	29	5	6	52	0.154	-0.043	0.876	0.039	0.039	0	46	45.2	70.1	138	135	0	31	30
2015	7	29	5	16	52	0.184	0	0.876	0.043	0.039	0	46.4	45.2	69.2	139	135	0	31	30
2015	7	29	5	26	52	0.22	0.01	0.876	0.039	0.036	0	48.6	46	67.5	143	138	0	30	31
2015	7	29	5	36	52	0.177	-0.043	0.876	0.039	0.036	0	47.3	45.6	68.8	141	136	0	31	30
2015	7	29	5	46	52	0.253	-0.079	0.876	0.039	0.039	0	48.6	46.9	67.5	143	139	0	30	30
2015	7	29	5	56	52	0.194	-0.033	0.876	0.033	0.03	0	46.9	45.6	69.2	140	136	0	31	30
2015	7	29	6	6	52	0.102	-0.03	0.876	0.039	0.039	0	44.7	44.3	70.1	135	133	0	31	30
2015	7	29	6	16	52	0.161	0.007	0.876	0.033	0.03	0	44.7	43.4	70.5	135	131	0	31	30
2015	7	29	6	26	52	0.144	0.01	0.876	0.033	0.03	0	42.6	42.1	72.2	129	128	0	30	30
2015	7	29	6	36	52	0.049	0.075	0.876	0.036	0.033	0	45.2	44.7	70.5	136	134	0	31	30
2015	7	29	6	46	52	0.151	-0.052	0.876	0.039	0.039	0	42.6	42.1	71.4	130	128	0	31	30
2015	7	29	6	56	52	0.2	-0.036	0.876	0.039	0.036	0	43	42.6	71.8	130	129	0	30	30
2015	7	29	7	6	52	0.131	-0.066	0.876	0.036	0.033	0	44.3	43.4	70.5	133	131	0	30	30
2015	7	29	7	16	52	0.174	-0.02	0.876	0.046	0.046	0	42.6	42.1	71.8	130	128	0	31	30
2015	7	29	7	26	52	0.167	0	0.876	0.039	0.036	0	43.9	43.9	70.5	133	132	0	31	30
2015	7	29	7	36	52	0.121	0.036	0.876	0.033	0.03	0	43.4	43.4	71.4	132	131	0	31	30
2015	7	29	7	46	52	0.213	-0.03	0.876	0.039	0.036	0	43	43.9	71	131	132	0	31	30
2015	7	29	7	56	52	0.177	-0.003	0.879	0.039	0.036	0	43	43.4	72.2	132	131	0	32	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	29	8	6	52	0.233	0.036	0.876	0.049	0.046	0	43	44.3	72.2	131	132	0	31	29
2015	7	29	8	16	52	0.135	0.013	0.879	0.039	0.036	0	42.1	42.6	72.2	129	129	0	31	30
2015	7	29	8	26	52	0.177	0.016	0.879	0.033	0.03	0	43.4	43	72.7	131	130	0	30	30
2015	7	29	8	36	52	0.141	-0.036	0.876	0.043	0.043	0	43	43	72.7	131	130	0	31	30
2015	7	29	8	46	52	0.18	0.039	0.876	0.033	0.03	0	43.4	43.9	72.2	132	132	0	31	30
2015	7	29	8	56	52	0.174	0.039	0.876	0.039	0.036	0	44.3	44.3	71.4	133	133	0	30	30
2015	7	29	9	6	52	0.131	0.033	0.876	0.033	0.03	0	45.2	44.7	71	136	134	0	31	30
2015	7	29	9	16	52	0.066	0.016	0.876	0.039	0.039	0	45.6	45.6	71.8	136	135	0	30	29
2015	7	29	9	26	52	0.066	0.016	0.876	0.039	0.036	0	44.7	43.9	71.4	135	133	0	31	31
2015	7	29	9	36	52	0.157	-0.046	0.876	0.036	0.033	0	46	45.2	71.8	138	135	0	31	30
2015	7	29	9	46	52	0.154	-0.003	0.876	0.039	0.036	0	44.7	45.2	71.4	135	135	0	31	30
2015	7	29	9	56	52	0.157	0.007	0.876	0.033	0.03	0	44.7	46	71	135	136	0	31	29
2015	7	29	10	6	52	0.131	-0.066	0.876	0.039	0.036	0	45.6	44.7	70.5	137	134	0	31	30
2015	7	29	10	16	52	0.164	0.082	0.876	0.033	0.03	0	45.6	45.6	71.4	137	136	0	31	30
2015	7	29	10	26	52	0.213	-0.013	0.876	0.043	0.043	0	50.3	48.2	63.6	147	142	0	30	30
2015	7	29	10	36	52	0.167	-0.052	0.886	0.033	0.03	0	44.3	43.4	73.5	134	131	0	31	30
2015	7	29	10	46	52	0.177	-0.066	0.883	0.039	0.036	0	46.9	46.4	73.1	139	137	0	30	29
2015	7	29	10	56	52	0.125	-0.01	0.883	0.036	0.033	0	46.9	46	72.7	139	137	0	30	30
2015	7	29	11	6	52	0.148	0.016	0.883	0.039	0.036	0	45.6	45.6	72.2	137	135	0	31	29
2015	7	29	11	16	52	0.184	0.023	0.883	0.033	0.03	0	45.2	45.6	71.8	135	136	0	30	30
2015	7	29	11	26	52	0.194	0.033	0.883	0.043	0.043	0	44.7	45.2	72.7	135	135	0	31	30
2015	7	29	11	36	52	0.203	-0.02	0.879	0.039	0.039	0	46	46	70.5	137	137	0	30	30
2015	7	29	11	46	52	0.217	-0.049	0.876	0.033	0.03	0	44.7	45.6	71.4	135	136	0	31	30
2015	7	29	11	56	52	0.161	-0.01	0.876	0.036	0.033	0	44.7	46.9	71.8	135	138	0	31	29
2015	7	29	12	6	52	0.161	-0.013	0.873	0.033	0.03	0	45.6	46.9	71	137	139	0	31	30
2015	7	29	12	16	52	0.115	0.016	0.873	0.033	0.03	0	46.4	46.9	70.5	139	139	0	31	30
2015	7	29	12	26	52	0.187	0.049	0.873	0.039	0.036	0	45.2	47.7	71	136	141	0	31	30
2015	7	29	12	36	52	0.2	0.056	0.869	0.033	0.03	0	48.2	48.6	70.1	142	143	0	30	30
2015	7	29	12	46	52	0.194	-0.01	0.869	0.033	0.03	0	48.2	49	70.1	142	143	0	30	29
2015	7	29	12	56	52	0.213	0	0.866	0.033	0.03	0	47.7	49.5	68.4	142	144	0	31	29
2015	7	29	13	6	52	0.141	0.079	0.869	0.033	0.03	0	49.9	49.9	68.4	147	146	0	31	30
2015	7	29	13	16	52	0.21	0.059	0.866	0.039	0.039	0	49.9	50.7	68.4	147	147	0	31	29
2015	7	29	13	26	52	0.128	-0.013	0.866	0.039	0.036	0	49.5	50.3	68.4	146	146	0	31	29
2015	7	29	13	36	52	0.19	0.075	0.866	0.033	0.03	0	48.6	50.3	71	144	146	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	29	13	46	52	0.217	0.043	0.866	0.039	0.036	0	49	50.3	70.1	144	146	0	30	29
2015	7	29	13	56	52	0.131	0.049	0.866	0.033	0.03	0	49.9	50.3	70.1	146	147	0	30	30
2015	7	29	14	6	52	0.154	0.092	0.866	0.033	0.03	0	49.5	50.3	70.5	145	146	0	30	29
2015	7	29	14	16	52	0.184	0.033	0.866	0.033	0.03	0	49	49.9	71	144	146	0	30	30
2015	7	29	14	26	52	0.2	0	0.866	0.033	0.03	0	49.5	49.9	70.1	145	146	0	30	30
2015	7	29	14	36	52	0.171	0.075	0.866	0.036	0.033	0	49.5	49.5	71	145	145	0	30	30
2015	7	29	14	46	52	0.19	0.125	0.866	0.039	0.036	0	49	51.2	71.8	144	148	0	30	29
2015	7	29	14	56	52	0.171	0.115	0.863	0.033	0.03	0	49	50.7	72.7	144	147	0	30	29
2015	7	29	15	6	52	0.135	0.069	0.866	0.033	0.03	0	49	50.3	72.7	144	146	0	30	29
2015	7	29	15	16	52	0.174	0.036	0.866	0.033	0.03	0	49	50.3	71.8	145	146	0	31	29
2015	7	29	15	26	52	0.151	0.092	0.866	0.033	0.03	0	49.5	49.9	71.4	145	146	0	30	30
2015	7	29	15	36	52	0.23	0.02	0.863	0.036	0.033	0	48.6	49.5	71.4	143	145	0	30	30
2015	7	29	15	46	52	0.262	0.02	0.863	0.033	0.03	0	49.5	49	72.7	145	144	0	30	30
2015	7	29	15	56	52	0.098	0.033	0.866	0.036	0.033	0	49.9	49.9	71.4	146	145	0	30	29
2015	7	29	16	6	52	0.18	0.03	0.863	0.039	0.039	0	51.6	51.2	69.2	150	148	0	30	29
2015	7	29	16	16	52	0.164	0	0.863	0.033	0.03	0	49.9	49	71	146	144	0	30	30
2015	7	29	16	26	52	0.138	-0.079	0.863	0.039	0.036	0	51.2	51.2	68.8	149	149	0	30	30
2015	7	29	16	36	52	0.161	0.036	0.863	0.036	0.033	0	49.9	49.5	70.5	146	144	0	30	29
2015	7	29	16	46	52	0.18	0.092	0.863	0.036	0.033	0	52.5	52.5	68.4	152	150	0	30	28
2015	7	29	16	56	52	0.217	0.154	0.863	0.033	0.03	0	53.3	52	67.1	154	150	0	30	29
2015	7	29	17	6	52	0.226	0.095	0.863	0.033	0.03	0	52.5	51.6	67.9	152	149	0	30	29
2015	7	29	17	16	52	0.187	0.092	0.863	0.036	0.033	0	51.6	50.7	68.4	150	147	0	30	29
2015	7	29	17	26	52	0.184	0.144	0.863	0.039	0.039	0	49.9	49	70.5	146	143	0	30	29
2015	7	29	17	36	52	0.154	0.128	0.863	0.033	0.03	0	49	48.6	70.5	144	142	0	30	29
2015	7	29	17	46	52	0.19	0.075	0.863	0.039	0.036	0	48.6	47.3	72.7	142	139	0	29	29
2015	7	29	17	56	52	0.161	0.049	0.863	0.043	0.039	0	47.3	46.9	72.7	140	138	0	30	29
2015	7	29	18	6	52	0.194	0.023	0.863	0.043	0.039	0	48.2	46.9	72.2	142	138	0	30	29
2015	7	29	18	16	52	0.161	0.003	0.863	0.049	0.046	0	47.3	46.4	72.2	140	137	0	30	29
2015	7	29	18	26	52	0.144	0.043	0.863	0.033	0.03	0	47.7	46	72.7	141	136	0	30	29
2015	7	29	18	36	52	0.121	0.003	0.863	0.036	0.033	0	46	44.3	74	137	132	0	30	29
2015	7	29	18	46	52	0.135	0.033	0.863	0.039	0.039	0	45.2	43.4	74.8	135	130	0	30	29
2015	7	29	18	56	52	0.164	-0.046	0.863	0.039	0.039	0	43.9	42.6	75.3	132	128	0	30	29
2015	7	29	19	6	52	0.171	-0.02	0.863	0.039	0.036	0	43.9	42.6	75.7	132	128	0	30	29
2015	7	29	19	16	52	0.131	-0.007	0.863	0.039	0.039	0	45.2	43.9	74.4	135	131	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	29	19	26	52	0.197	-0.013	0.863	0.036	0.033	0	43.9	41.7	76.1	132	126	0	30	29
2015	7	29	19	36	52	0.115	0	0.863	0.039	0.036	0	44.7	43.9	74.8	134	132	0	30	30
2015	7	29	19	46	52	0.161	-0.016	0.863	0.039	0.036	0	45.6	43.9	74.4	136	131	0	30	29
2015	7	29	19	56	52	0.135	-0.007	0.863	0.033	0.03	0	46.4	45.2	73.5	138	134	0	30	29
2015	7	29	20	6	52	0.171	-0.003	0.863	0.039	0.039	0	44.7	43.9	74.4	134	131	0	30	29
2015	7	29	20	16	52	0.177	-0.089	0.863	0.039	0.039	0	44.7	43.4	75.7	135	130	0	31	29
2015	7	29	20	26	52	0.148	0.036	0.863	0.039	0.036	0	45.2	44.3	74.8	135	132	0	30	29
2015	7	29	20	36	52	0.171	0.016	0.863	0.036	0.033	0	46.9	45.2	73.5	139	134	0	30	29
2015	7	29	20	46	52	0.223	-0.016	0.863	0.039	0.036	0	46.9	45.2	73.1	139	134	0	30	29
2015	7	29	20	56	52	0.148	-0.036	0.863	0.039	0.036	0	46.4	44.3	73.5	138	133	0	30	30
2015	7	29	21	6	52	0.167	-0.039	0.863	0.039	0.036	0	46	44.3	74	137	132	0	30	29
2015	7	29	21	16	52	0.141	0	0.86	0.039	0.036	0	47.3	45.6	73.1	140	135	0	30	29
2015	7	29	21	26	52	0.108	0.062	0.863	0.039	0.039	0	45.6	44.3	73.5	136	132	0	30	29
2015	7	29	21	36	52	0.19	0.075	0.863	0.039	0.036	0	46	44.7	73.1	137	133	0	30	29
2015	7	29	21	46	52	0.105	0.033	0.86	0.039	0.036	0	46.4	44.7	73.5	138	133	0	30	29
2015	7	29	21	56	52	0.18	0	0.86	0.036	0.033	0	47.3	45.6	73.5	140	135	0	30	29
2015	7	29	22	6	52	0.203	-0.03	0.86	0.039	0.039	0	51.2	49.9	68.8	149	145	0	30	29
2015	7	29	22	16	52	0.154	-0.003	0.86	0.033	0.03	0	46.9	46	73.5	139	136	0	30	29
2015	7	29	22	26	52	0.184	0.003	0.86	0.036	0.033	0	46.9	44.7	72.2	139	134	0	30	30
2015	7	29	22	36	52	0.125	-0.036	0.86	0.036	0.033	0	46	44.7	74	137	133	0	30	29
2015	7	29	22	46	52	0.171	-0.036	0.86	0.039	0.036	0	48.2	46	72.7	142	136	0	30	29
2015	7	29	22	56	52	0.102	-0.023	0.86	0.036	0.033	0	48.6	46.4	71.8	143	137	0	30	29
2015	7	29	23	6	52	0.19	0.03	0.86	0.043	0.039	0	48.6	46.9	72.2	143	138	0	30	29
2015	7	29	23	16	52	0.19	0	0.86	0.043	0.039	0	50.7	48.2	69.2	148	142	0	30	30
2015	7	29	23	26	52	0.164	-0.062	0.86	0.043	0.039	0	51.6	49.9	67.5	150	145	0	30	29
2015	7	29	23	36	52	0.187	-0.03	0.86	0.036	0.033	0	50.3	48.2	70.5	147	142	0	30	30
2015	7	29	23	46	52	0.18	-0.046	0.86	0.039	0.036	0	51.6	49.5	68.8	150	145	0	30	30
2015	7	29	23	56	52	0.135	-0.023	0.86	0.036	0.033	0	49	47.7	71.4	144	140	0	30	29
2015	7	30	0	6	52	0.2	0	0.86	0.046	0.043	0	49	47.7	71	144	140	0	30	29
2015	7	30	0	16	52	0.112	-0.016	0.856	0.039	0.036	0	52.9	50.7	67.5	153	147	0	30	29
2015	7	30	0	26	52	0.141	-0.069	0.86	0.046	0.043	0	50.7	49.5	69.2	148	144	0	30	29
2015	7	30	0	36	52	0.085	0.007	0.86	0.033	0.03	0	50.3	48.6	69.7	147	143	0	30	30
2015	7	30	0	46	52	0.112	0.026	0.86	0.043	0.039	0	49.5	46.9	70.5	145	139	0	30	30
2015	7	30	0	56	52	0.157	-0.023	0.86	0.046	0.043	0	45.2	43.9	74.8	135	131	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	30	1	6	52	0.131	-0.033	0.86	0.036	0.033	0	45.2	43.4	75.3	135	130	0	30	29
2015	7	30	1	16	52	0.131	-0.016	0.86	0.039	0.036	0	44.7	43.4	74.4	134	131	0	30	30
2015	7	30	1	26	52	0.148	-0.036	0.86	0.036	0.033	0	46.9	45.6	73.1	139	135	0	30	29
2015	7	30	1	36	52	0.135	-0.039	0.86	0.036	0.033	0	43	41.7	76.5	130	126	0	30	29
2015	7	30	1	46	52	0.226	-0.026	0.86	0.036	0.033	0	43.4	42.6	76.1	131	129	0	30	30
2015	7	30	1	56	52	0.144	-0.039	0.856	0.039	0.036	0	51.6	49	69.7	149	144	0	29	30
2015	7	30	2	6	52	0.138	-0.033	0.86	0.039	0.036	0	49.9	49	69.7	147	143	0	31	29
2015	7	30	2	16	52	0.135	0.013	0.86	0.039	0.036	0	52.5	49.9	68.4	152	146	0	30	30
2015	7	30	2	26	52	0.207	-0.092	0.86	0.039	0.039	0	52.5	50.3	67.5	151	146	0	29	29
2015	7	30	2	36	52	0.161	-0.003	0.86	0.033	0.03	0	49	47.3	71	144	139	0	30	29
2015	7	30	2	46	52	0.026	0.02	0.86	0.033	0.03	0	47.3	46	72.2	141	137	0	31	30
2015	7	30	2	56	52	0.148	-0.02	0.86	0.039	0.036	0	48.2	46	71.4	142	137	0	30	30
2015	7	30	3	6	52	0.207	0.03	0.86	0.036	0.033	0	47.7	46.4	71.8	141	138	0	30	30
2015	7	30	3	16	52	0.151	0.03	0.86	0.039	0.036	0	46.4	44.3	74	138	132	0	30	29
2015	7	30	3	26	52	0.187	-0.01	0.86	0.043	0.039	0	49.9	48.2	69.7	147	142	0	31	30
2015	7	30	3	36	52	0.184	-0.052	0.86	0.039	0.039	0	52.5	50.3	67.9	152	146	0	30	29
2015	7	30	3	46	52	0.174	-0.079	0.86	0.039	0.039	0	51.6	49.5	67.9	150	145	0	30	30
2015	7	30	3	56	52	0.128	-0.049	0.86	0.039	0.039	0	51.6	49.5	68.4	150	144	0	30	29
2015	7	30	4	6	52	0.194	-0.075	0.86	0.039	0.039	0	50.7	49.5	69.2	148	144	0	30	29
2015	7	30	4	16	52	0.118	-0.046	0.86	0.043	0.039	0	45.6	43.9	74	136	132	0	30	30
2015	7	30	4	26	52	0.098	-0.003	0.86	0.036	0.033	0	44.3	44.7	73.5	134	133	0	31	29
2015	7	30	4	36	52	0.174	-0.085	0.86	0.033	0.03	0	43.4	43.4	74.4	132	130	0	31	29
2015	7	30	4	46	52	0.217	-0.01	0.86	0.039	0.036	0	45.2	44.3	73.5	135	132	0	30	29
2015	7	30	4	56	52	0.089	-0.007	0.863	0.043	0.039	0	44.3	43.4	74	133	130	0	30	29
2015	7	30	5	6	52	0.236	-0.033	0.863	0.039	0.036	0	43.9	43.4	74.8	133	130	0	31	29
2015	7	30	5	16	52	0.187	-0.003	0.86	0.039	0.036	0	48.6	46.9	69.7	143	138	0	30	29
2015	7	30	5	26	52	0.131	-0.026	0.86	0.039	0.036	0	50.3	49.5	67.5	147	145	0	30	30
2015	7	30	5	36	52	0.118	-0.03	0.86	0.043	0.039	0	50.3	48.6	67.5	147	143	0	30	30
2015	7	30	5	46	52	0.21	-0.01	0.86	0.043	0.039	0	48.6	47.3	69.7	143	139	0	30	29
2015	7	30	5	56	52	0.164	-0.016	0.86	0.039	0.036	0	48.2	46.9	70.5	143	138	0	31	29
2015	7	30	6	6	52	0.148	-0.013	0.86	0.043	0.039	0	47.7	46.4	71	141	137	0	30	29
2015	7	30	6	16	52	0.171	0.066	0.86	0.036	0.033	0	49	47.3	69.7	144	140	0	30	30
2015	7	30	6	26	52	0.138	0.049	0.863	0.039	0.036	0	46	44.7	71.8	137	134	0	30	30
2015	7	30	6	36	52	0.2	0.125	0.86	0.039	0.036	0	53.8	52.5	64.5	155	151	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	30	6	46	52	0.226	0.121	0.86	0.036	0.033	0	51.6	49.9	66.7	150	146	0	30	30
2015	7	30	6	56	52	0.125	0.072	0.86	0.039	0.039	0	51.2	49.5	66.7	149	145	0	30	30
2015	7	30	7	6	52	0.098	-0.066	0.863	0.039	0.036	0	49.9	48.2	68.4	146	142	0	30	30
2015	7	30	7	16	52	0.115	0	0.863	0.033	0.03	0	46.9	45.2	71.4	140	135	0	31	30
2015	7	30	7	26	52	0.141	-0.03	0.863	0.039	0.036	0	47.3	46	70.5	140	136	0	30	29
2015	7	30	7	36	52	0.108	-0.046	0.863	0.033	0.03	0	46.4	45.6	71.4	138	135	0	30	29
2015	7	30	7	46	52	0.2	-0.033	0.863	0.039	0.039	0	47.7	46.4	69.2	141	137	0	30	29
2015	7	30	7	56	52	0.102	-0.013	0.863	0.043	0.039	0	46	45.2	71.4	138	135	0	31	30
2015	7	30	8	6	52	0.148	-0.046	0.863	0.039	0.036	0	45.6	43.4	72.2	136	132	0	30	31
2015	7	30	8	16	52	0.174	-0.03	0.863	0.039	0.036	0	45.2	44.3	72.7	136	133	0	31	30
2015	7	30	8	26	52	0.184	-0.062	0.863	0.033	0.03	0	45.2	44.3	72.2	135	133	0	30	30
2015	7	30	8	36	52	0.266	0.036	0.863	0.036	0.033	0	45.2	44.3	72.2	136	132	0	31	29
2015	7	30	8	46	52	0.138	-0.059	0.863	0.039	0.036	0	43	43	73.5	131	129	0	31	29
2015	7	30	8	56	52	0.174	0.046	0.863	0.033	0.03	0	46	45.2	70.5	138	135	0	31	30
2015	7	30	9	6	52	0.164	-0.046	0.863	0.033	0.03	0	43.9	43.4	73.5	133	131	0	31	30
2015	7	30	9	16	52	0.148	-0.02	0.863	0.039	0.036	0	44.7	45.2	72.2	135	134	0	31	29
2015	7	30	9	26	52	0.213	-0.039	0.863	0.033	0.03	0	44.3	43.9	73.1	133	131	0	30	29
2015	7	30	9	36	52	0.207	0.052	0.863	0.043	0.039	0	45.6	44.3	73.1	136	133	0	30	30
2015	7	30	9	46	52	0.21	0.033	0.863	0.039	0.036	0	47.7	46.9	70.5	141	139	0	30	30
2015	7	30	9	56	52	0.213	-0.03	0.863	0.039	0.036	0	48.2	47.3	70.1	142	140	0	30	30
2015	7	30	10	14	31	0.167	-0.013	0.866	0.033	0.03	0	46.4	45.6	72.2	139	136	0	31	30
2015	7	30	10	24	31	0.141	-0.079	0.863	0.039	0.036	0	46.4	45.6	71.4	139	136	0	31	30
2015	7	30	10	34	31	0.144	0	0.863	0.036	0.033	0	48.6	47.7	69.7	144	141	0	31	30
2015	7	30	10	44	31	0.138	-0.036	0.863	0.039	0.036	0	49.5	49.5	69.2	145	144	0	30	29
2015	7	30	10	54	31	0.184	-0.052	0.866	0.043	0.039	0	49.5	48.2	69.7	146	142	0	31	30
2015	7	30	11	4	31	0.174	-0.046	0.863	0.036	0.033	0	51.2	49.5	69.2	149	144	0	30	29
2015	7	30	11	14	31	0.148	-0.003	0.863	0.033	0.03	0	51.6	50.3	68.4	150	146	0	30	29
2015	7	30	11	24	31	0.115	0.016	0.863	0.036	0.033	0	50.7	50.3	69.2	149	146	0	31	29
2015	7	30	11	34	31	0.141	0	0.863	0.043	0.039	0	49.9	48.2	69.7	147	142	0	31	30
2015	7	30	11	44	31	0.112	0	0.863	0.033	0.03	0	50.3	49.5	70.1	147	144	0	30	29
2015	7	30	11	54	31	0.18	-0.052	0.863	0.043	0.039	0	51.2	49.9	68.8	149	145	0	30	29
2015	7	30	12	4	31	0.19	0	0.863	0.036	0.033	0	52	51.2	67.5	151	148	0	30	29
2015	7	30	12	14	31	0.207	-0.013	0.863	0.039	0.036	0	51.6	50.7	68.8	150	148	0	30	30
2015	7	30	12	24	31	0.187	-0.056	0.863	0.036	0.033	0	50.3	49.9	69.7	147	145	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	30	12	34	31	0.075	-0.026	0.863	0.033	0.03	0	49	49	70.5	145	144	0	31	30
2015	7	30	12	44	31	0.085	0	0.863	0.033	0.03	0	51.6	50.3	68.4	151	147	0	31	30
2015	7	30	12	54	31	0.135	-0.052	0.863	0.039	0.036	0	51.6	49.5	69.7	149	145	0	29	30
2015	7	30	13	4	31	0.213	-0.03	0.863	0.036	0.033	0	52.5	51.6	68.4	152	149	0	30	29
2015	7	30	13	14	31	0.112	-0.016	0.863	0.039	0.036	0	52.5	51.6	68.8	152	150	0	30	30
2015	7	30	13	24	31	0.207	0.016	0.863	0.039	0.039	0	53.3	52	67.9	154	150	0	30	29
2015	7	30	13	34	31	0.144	0.016	0.863	0.033	0.03	0	52.9	52	67.9	153	150	0	30	29
2015	7	30	13	44	31	0.2	0.02	0.863	0.033	0.03	0	52.9	51.6	69.2	153	149	0	30	29
2015	7	30	13	54	31	0.187	0.007	0.863	0.039	0.039	0	52.5	52.5	67.9	153	151	0	31	29
2015	7	30	14	4	31	0.131	0	0.863	0.033	0.03	0	53.3	52	67.9	154	150	0	30	29
2015	7	30	14	14	31	0.138	0.082	0.863	0.033	0.03	0	52.9	52	67.9	153	150	0	30	29
2015	7	30	14	24	31	0.187	0.007	0.863	0.033	0.03	0	53.8	52	68.8	155	150	0	30	29
2015	7	30	14	34	31	0.2	0.036	0.863	0.039	0.036	0	52.5	51.6	68.4	153	150	0	31	30
2015	7	30	14	44	31	0.151	-0.036	0.863	0.033	0.03	0	52	52	67.9	152	150	0	31	29
2015	7	30	14	54	31	0.164	-0.007	0.863	0.043	0.039	0	56.3	54.2	65.8	161	155	0	30	29
2015	7	30	15	4	31	0.187	-0.072	0.863	0.039	0.036	0	55.9	53.8	65.4	160	154	0	30	29
2015	7	30	15	14	31	0.112	0.03	0.863	0.036	0.033	0	57.2	54.6	64.1	163	157	0	30	30
2015	7	30	15	24	31	0.184	0.01	0.863	0.039	0.036	0	55.5	53.8	65.8	158	154	0	29	29
2015	7	30	15	34	31	0.177	0.036	0.863	0.036	0.033	0	53.3	52	67.9	154	150	0	30	29
2015	7	30	15	44	31	0.21	0.013	0.863	0.036	0.033	0	51.2	49.5	68.8	149	145	0	30	30
2015	7	30	15	54	31	0.148	-0.023	0.863	0.033	0.03	0	50.3	50.3	68.4	148	146	0	31	29
2015	7	30	16	4	31	0.203	-0.075	0.863	0.039	0.039	0	55.9	54.2	63.6	160	155	0	30	29
2015	7	30	16	14	31	0.187	0	0.863	0.043	0.039	0	52.5	50.7	66.2	152	147	0	30	29
2015	7	30	16	24	31	0.157	0.108	0.86	0.043	0.039	0	52	50.7	65.4	151	147	0	30	29
2015	7	30	16	34	31	0.161	0.092	0.863	0.039	0.036	0	51.2	49.9	68.8	149	145	0	30	29
2015	7	30	16	44	31	0.138	0.01	0.863	0.036	0.033	0	50.7	49	69.2	148	143	0	30	29
2015	7	30	16	54	31	0.187	0.049	0.863	0.036	0.033	0	49	47.3	71.4	144	140	0	30	30
2015	7	30	17	4	31	0.171	0.036	0.863	0.046	0.043	0	48.2	46.9	70.5	143	139	0	31	30
2015	7	30	17	14	31	0.128	0.043	0.863	0.036	0.033	0	47.7	46	71.8	141	136	0	30	29
2015	7	30	17	24	31	0.161	0.049	0.863	0.036	0.033	0	47.7	46.9	72.2	141	138	0	30	29
2015	7	30	17	34	31	0.148	0.036	0.863	0.039	0.036	0	47.7	46	71.4	141	137	0	30	30
2015	7	30	17	44	31	0.207	0.033	0.863	0.036	0.033	0	49.9	48.6	69.7	146	142	0	30	29
2015	7	30	17	54	31	0.072	0.003	0.863	0.043	0.039	0	51.6	50.3	63.2	150	146	0	30	29
2015	7	30	18	4	31	0.171	0.01	0.863	0.036	0.033	0	51.6	49.9	67.1	150	145	0	30	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	30	18	14	31	0.131	-0.01	0.863	0.033	0.03	0	51.6	50.7	67.9	150	147	0	30	29
2015	7	30	18	24	31	0.22	0	0.863	0.039	0.036	0	48.6	47.7	68.8	144	141	0	31	30
2015	7	30	18	34	31	0.141	-0.007	0.863	0.039	0.039	0	49	47.3	68.4	145	139	0	31	29
2015	7	30	18	44	31	0.249	0.016	0.863	0.033	0.03	0	50.7	49	67.9	148	144	0	30	30
2015	7	30	18	54	31	0.148	0.112	0.863	0.036	0.033	0	50.7	49	69.2	148	143	0	30	29
2015	7	30	19	4	31	0.184	0.049	0.863	0.036	0.033	0	50.3	49.5	66.2	148	145	0	31	30
2015	7	30	19	14	31	0.138	0.098	0.863	0.043	0.039	0	50.3	49.5	67.9	148	144	0	31	29
2015	7	30	19	24	31	0.21	0.003	0.863	0.036	0.033	0	50.3	48.6	69.2	147	142	0	30	29
2015	7	30	19	34	31	0.131	0.049	0.863	0.036	0.033	0	49.9	48.6	68.8	146	142	0	30	29
2015	7	30	19	44	31	0.194	0.056	0.863	0.046	0.043	0	50.3	49.5	67.9	148	144	0	31	29
2015	7	30	19	54	31	0.164	0.085	0.863	0.039	0.036	0	48.6	47.3	70.1	143	140	0	30	30
2015	7	30	20	4	31	0.207	0.049	0.863	0.033	0.03	0	48.6	47.3	71	143	139	0	30	29
2015	7	30	20	14	31	0.207	0.023	0.863	0.036	0.033	0	49	47.7	69.7	144	140	0	30	29
2015	7	30	20	24	31	0.21	0.036	0.863	0.036	0.033	0	48.2	46.4	71	142	137	0	30	29
2015	7	30	20	34	31	0.167	0.052	0.863	0.033	0.03	0	49	47.3	69.2	144	139	0	30	29
2015	7	30	20	44	31	0.236	0.112	0.863	0.036	0.033	0	47.7	46.4	71.4	141	137	0	30	29
2015	7	30	20	54	31	0.2	0.098	0.863	0.036	0.033	0	47.7	46.4	70.5	141	137	0	30	29
2015	7	30	21	4	31	0.223	0.016	0.863	0.036	0.033	0	49.5	46.9	67.1	145	139	0	30	30
2015	7	30	21	14	31	0.167	0.128	0.866	0.049	0.046	0	47.3	46	69.7	141	136	0	31	29
2015	7	30	21	24	31	0.164	0.052	0.866	0.039	0.039	0	48.2	46.4	70.5	142	137	0	30	29
2015	7	30	21	34	31	0.177	-0.003	0.866	0.036	0.033	0	48.6	47.7	69.7	144	140	0	31	29
2015	7	30	21	44	31	0.154	0.066	0.866	0.033	0.03	0	48.2	47.3	69.7	143	139	0	31	29
2015	7	30	21	54	31	0.19	0.125	0.866	0.033	0.03	0	48.6	47.3	69.2	143	139	0	30	29
2015	7	30	22	4	31	0.18	0.072	0.866	0.033	0.03	0	48.6	46.9	69.2	144	139	0	31	30
2015	7	30	22	14	31	0.207	0.075	0.866	0.046	0.043	0	46.9	45.6	70.5	139	135	0	30	29
2015	7	30	22	24	31	0.148	0.151	0.866	0.033	0.03	0	47.7	45.6	69.7	141	135	0	30	29
2015	7	30	22	34	31	0.203	0	0.866	0.039	0.036	0	48.2	46	69.7	142	136	0	30	29
2015	7	30	22	44	31	0.213	0.108	0.866	0.036	0.033	0	46.4	45.6	71	139	135	0	31	29
2015	7	30	22	54	31	0.135	0.062	0.866	0.039	0.036	0	47.3	46	70.1	140	136	0	30	29
2015	7	30	23	4	31	0.184	0.036	0.866	0.039	0.039	0	46.4	44.3	71.4	138	133	0	30	30
2015	7	30	23	14	31	0.203	0.085	0.866	0.03	0.03	0	46	44.3	71.4	137	132	0	30	29
2015	7	30	23	24	31	0.148	0.092	0.866	0.039	0.036	0	45.6	44.7	71	136	133	0	30	29
2015	7	30	23	34	31	0.184	0.056	0.866	0.039	0.036	0	46	44.7	71.4	137	133	0	30	29
2015	7	30	23	44	31	0.344	0.059	0.866	0.036	0.033	0	46	44.3	71	138	133	0	31	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	30	23	54	31	0.203	0.023	0.866	0.036	0.033	0	45.6	44.7	71.4	136	133	0	30	29
2015	7	31	0	4	31	0.256	0.049	0.866	0.039	0.036	0	45.6	46	70.5	136	136	0	30	29
2015	7	31	0	14	31	0.131	0.016	0.866	0.036	0.033	0	45.6	43.9	71.4	136	132	0	30	30
2015	7	31	0	24	31	0.217	0.01	0.866	0.036	0.033	0	45.2	45.2	71.4	136	134	0	31	29
2015	7	31	0	34	31	0.236	-0.036	0.866	0.039	0.036	0	46.9	46	69.2	139	136	0	30	29
2015	7	31	0	44	31	0.118	-0.007	0.866	0.033	0.03	0	44.3	43.9	71.8	133	131	0	30	29
2015	7	31	0	54	31	0.167	0	0.866	0.049	0.046	0	45.2	43.4	71.4	135	131	0	30	30
2015	7	31	1	4	31	0.203	0.056	0.866	0.039	0.036	0	44.3	43	72.2	133	130	0	30	30
2015	7	31	1	14	31	0.164	0	0.866	0.039	0.036	0	44.7	44.3	71.8	134	132	0	30	29
2015	7	31	1	24	31	0.171	0	0.866	0.033	0.03	0	43.9	43.4	71.8	132	130	0	30	29
2015	7	31	1	34	31	0.207	-0.062	0.866	0.036	0.033	0	44.7	43.9	71.4	134	132	0	30	30
2015	7	31	1	44	31	0.256	0.043	0.866	0.033	0.03	0	44.3	43.4	71.4	133	130	0	30	29
2015	7	31	1	54	31	0.203	0	0.866	0.039	0.039	0	49.5	47.3	67.5	145	140	0	30	30
2015	7	31	2	4	31	0.161	0.003	0.869	0.043	0.039	0	45.2	44.3	71	135	133	0	30	30
2015	7	31	2	14	31	0.18	0.135	0.866	0.039	0.039	0	51.6	50.3	64.9	150	147	0	30	30
2015	7	31	2	24	31	0.19	0	0.866	0.043	0.043	0	50.7	49	66.7	148	144	0	30	30
2015	7	31	2	34	31	0.167	0	0.866	0.043	0.039	0	45.2	43.9	70.5	135	132	0	30	30
2015	7	31	2	44	31	0.148	0.013	0.869	0.039	0.036	0	45.2	44.3	71	135	132	0	30	29
2015	7	31	2	54	31	0.174	-0.007	0.869	0.039	0.036	0	43.9	44.3	71.4	132	132	0	30	29
2015	7	31	3	4	31	0.138	-0.02	0.869	0.039	0.036	0	43	43	71.4	131	130	0	31	30
2015	7	31	3	14	31	0.108	-0.075	0.866	0.039	0.036	0	46.4	45.2	69.7	139	135	0	31	30
2015	7	31	3	24	31	0.184	-0.039	0.869	0.036	0.033	0	43	43.4	72.2	130	130	0	30	29
2015	7	31	3	34	31	0.22	0.003	0.869	0.033	0.03	0	43.9	43	71.8	132	129	0	30	29
2015	7	31	3	44	31	0.148	0.033	0.869	0.033	0.03	0	43.4	43	71	131	129	0	30	29
2015	7	31	3	54	31	0.207	0.007	0.869	0.039	0.036	0	44.3	43.9	70.1	133	132	0	30	30
2015	7	31	4	4	31	0.2	-0.082	0.869	0.036	0.033	0	44.7	43	71.4	135	130	0	31	30
2015	7	31	4	14	31	0.184	-0.007	0.869	0.036	0.033	0	48.2	46.9	67.9	142	138	0	30	29
2015	7	31	4	24	31	0.203	-0.056	0.876	0.039	0.036	0	45.2	44.7	69.7	136	133	0	31	29
2015	7	31	4	34	31	0.2	-0.023	0.873	0.039	0.036	0	46.4	44.7	70.1	138	133	0	30	29
2015	7	31	4	44	31	0.223	0	0.876	0.033	0.03	0	45.6	44.3	71	137	133	0	31	30
2015	7	31	4	54	31	0.151	-0.036	0.873	0.039	0.036	0	44.7	44.3	71.4	134	132	0	30	29
2015	7	31	5	4	31	0.108	-0.089	0.873	0.039	0.036	0	49.9	48.6	65.8	147	142	0	31	29
2015	7	31	5	14	31	0.213	-0.085	0.876	0.049	0.046	0	50.7	48.2	66.2	148	142	0	30	30
2015	7	31	5	24	31	0.246	0.007	0.873	0.039	0.039	0	47.7	47.7	67.1	142	140	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	31	5	34	31	0.174	-0.03	0.876	0.039	0.036	0	50.3	48.2	65.8	147	141	0	30	29
2015	7	31	5	44	31	0.2	-0.007	0.876	0.033	0.03	0	48.6	47.3	67.1	143	139	0	30	29
2015	7	31	5	54	31	0.164	-0.052	0.876	0.033	0.03	0	47.7	46.4	68.4	141	138	0	30	30
2015	7	31	6	4	31	0.161	0.01	0.876	0.039	0.036	0	46.4	45.6	68.8	138	136	0	30	30
2015	7	31	6	14	31	0.184	0	0.876	0.039	0.039	0	47.3	46.4	68.8	141	137	0	31	29
2015	7	31	6	24	31	0.249	-0.033	0.879	0.039	0.036	0	46	45.2	70.5	137	134	0	30	29
2015	7	31	6	34	31	0.236	-0.075	0.876	0.036	0.033	0	47.3	46	67.9	140	137	0	30	30
2015	7	31	6	44	31	0.154	-0.033	0.879	0.033	0.03	0	43	42.1	72.2	131	128	0	31	30
2015	7	31	6	54	31	0.184	-0.075	0.879	0.033	0.03	0	44.3	43.4	71.8	134	131	0	31	30
2015	7	31	7	4	31	0.115	0.01	0.876	0.036	0.033	0	44.3	43.4	71.4	134	131	0	31	30
2015	7	31	7	14	31	0.171	-0.016	0.876	0.039	0.036	0	45.2	45.2	70.1	136	134	0	31	29
2015	7	31	7	24	31	0.276	-0.075	0.876	0.039	0.036	0	47.7	46.9	68.4	141	138	0	30	29
2015	7	31	7	34	31	0.167	-0.056	0.879	0.039	0.036	0	45.2	43.9	70.5	135	132	0	30	30
2015	7	31	7	44	31	0.197	0	0.876	0.033	0.03	0	45.2	45.6	69.7	136	135	0	31	29
2015	7	31	7	54	31	0.207	0.039	0.879	0.036	0.033	0	45.6	45.2	71	137	135	0	31	30
2015	7	31	8	4	31	0.144	-0.036	0.879	0.033	0.03	0	46	46	70.5	138	137	0	31	30
2015	7	31	8	14	31	0.121	0.049	0.876	0.036	0.033	0	45.6	45.2	70.1	136	135	0	30	30
2015	7	31	8	24	31	0.194	0.043	0.876	0.033	0.03	0	44.7	44.3	71	135	133	0	31	30
2015	7	31	8	34	31	0.118	0.007	0.879	0.036	0.033	0	44.3	43.9	71.4	133	132	0	30	30
2015	7	31	8	44	31	0.233	0.033	0.879	0.039	0.039	0	43.9	44.7	70.5	133	134	0	31	30
2015	7	31	8	54	31	0.253	-0.036	0.873	0.033	0.03	0	46	45.2	68.8	137	135	0	30	30
2015	7	31	9	4	31	0.259	0.01	0.876	0.043	0.039	0	46	45.6	68.8	138	135	0	31	29
2015	7	31	9	14	31	0.213	-0.007	0.876	0.036	0.033	0	45.6	45.6	70.5	137	136	0	31	30
2015	7	31	9	24	31	0.187	-0.043	0.876	0.039	0.036	0	47.7	46.9	67.5	142	139	0	31	30
2015	7	31	9	34	31	0.171	0.043	0.876	0.033	0.03	0	46.9	46	70.1	139	137	0	30	30
2015	7	31	9	44	31	0.23	-0.039	0.876	0.033	0.03	0	46.4	46	69.7	139	137	0	31	30
2015	7	31	9	54	31	0.151	0.007	0.879	0.033	0.03	0	46.9	46	68.8	140	137	0	31	30
2015	7	31	10	4	31	0.141	0.013	0.876	0.033	0.03	0	46.9	46	71	139	137	0	30	30
2015	7	31	10	14	31	0.148	0.003	0.879	0.039	0.036	0	46	46	71	138	137	0	31	30
2015	7	31	10	24	31	0.2	-0.01	0.876	0.033	0.033	0	47.3	46.4	71	140	138	0	30	30
2015	7	31	10	34	31	0.135	0	0.876	0.039	0.036	0	46.4	47.7	69.7	139	141	0	31	30
2015	7	31	10	44	31	0.2	-0.007	0.876	0.033	0.03	0	46	46.4	70.5	138	138	0	31	30
2015	7	31	10	54	31	0.148	0.003	0.876	0.036	0.033	0	47.3	46	70.5	140	137	0	30	30
2015	7	31	11	4	31	0.164	0.007	0.876	0.033	0.03	0	47.7	47.7	71	141	141	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	31	11	14	31	0.207	-0.046	0.873	0.036	0.033	0	47.7	48.2	68.8	142	142	0	31	30
2015	7	31	11	24	31	0.157	0.007	0.876	0.033	0.03	0	47.7	46.9	70.5	140	139	0	29	30
2015	7	31	11	34	31	0.217	0.059	0.876	0.039	0.036	0	47.7	46.9	69.7	141	139	0	30	30
2015	7	31	11	44	31	0.144	0.016	0.876	0.03	0.03	0	46.9	46.9	70.5	139	139	0	30	30
2015	7	31	11	54	31	0.2	0.007	0.876	0.033	0.03	0	48.2	48.2	71.4	142	141	0	30	29
2015	7	31	12	4	31	0.194	0	0.873	0.036	0.033	0	47.3	47.7	70.1	141	140	0	31	29
2015	7	31	12	14	31	0.2	0.026	0.873	0.039	0.036	0	48.6	48.2	70.5	144	142	0	31	30
2015	7	31	12	24	31	0.194	0.033	0.873	0.033	0.03	0	50.3	49.9	69.7	147	146	0	30	30
2015	7	31	12	34	31	0.112	0.033	0.873	0.039	0.036	0	51.2	50.3	67.1	149	147	0	30	30
2015	7	31	12	44	31	0.164	0.007	0.873	0.033	0.03	0	50.3	49.9	69.2	148	146	0	31	30
2015	7	31	12	54	31	0.128	0.033	0.873	0.039	0.039	0	52	51.2	67.1	152	149	0	31	30
2015	7	31	13	4	31	0.2	0.102	0.869	0.039	0.036	0	52.9	52.5	66.2	154	151	0	31	29
2015	7	31	13	14	31	0.135	0	0.869	0.036	0.033	0	52.9	52.9	67.5	153	152	0	30	29
2015	7	31	13	24	31	0.161	0.033	0.869	0.036	0.033	0	52.5	51.2	67.1	152	149	0	30	30
2015	7	31	13	34	31	0.207	0.023	0.869	0.039	0.036	0	51.6	51.6	67.1	151	150	0	31	30
2015	7	31	13	44	31	0.24	0.016	0.869	0.036	0.033	0	52	52	68.8	152	151	0	31	30
2015	7	31	13	54	31	0.223	0.033	0.869	0.036	0.033	0	52.9	52.9	66.7	153	153	0	30	30
2015	7	31	14	4	31	0.164	0.128	0.869	0.033	0.03	0	52.9	52.5	66.7	153	152	0	30	30
2015	7	31	14	14	31	0.171	0.02	0.866	0.033	0.03	0	54.2	53.8	65.4	156	154	0	30	29
2015	7	31	14	24	31	0.148	0.108	0.866	0.033	0.03	0	52	53.3	68.4	152	153	0	31	29
2015	7	31	14	34	31	0.148	0.049	0.866	0.039	0.036	0	53.3	53.8	65.8	155	155	0	31	30
2015	7	31	14	44	31	0.194	0.082	0.866	0.036	0.033	0	52.9	52.5	67.1	154	152	0	31	30
2015	7	31	14	54	31	0.138	0.026	0.866	0.033	0.03	0	52.9	53.3	67.5	154	153	0	31	29
2015	7	31	15	4	31	0.174	0.039	0.866	0.036	0.033	0	52	52	68.8	152	151	0	31	30
2015	7	31	15	14	31	0.2	0.072	0.866	0.033	0.03	0	54.6	54.2	67.5	157	156	0	30	30
2015	7	31	15	24	31	0.157	-0.013	0.866	0.033	0.03	0	54.2	54.2	65.4	157	156	0	31	30
2015	7	31	15	34	31	0.131	0.075	0.866	0.039	0.036	0	53.8	53.3	66.7	156	154	0	31	30
2015	7	31	15	44	31	0.148	0.026	0.866	0.033	0.03	0	53.8	53.3	68.8	155	154	0	30	30
2015	7	31	15	54	31	0.217	0.016	0.863	0.039	0.036	0	54.2	54.6	67.5	157	156	0	31	29
2015	7	31	16	4	31	0.164	-0.023	0.863	0.033	0.03	0	54.2	53.8	65.4	156	154	0	30	29
2015	7	31	16	14	31	0.128	0.039	0.866	0.039	0.036	0	55	55	66.7	159	157	0	31	29
2015	7	31	16	24	31	0.207	0.046	0.866	0.036	0.033	0	55.5	54.2	66.2	159	156	0	30	30
2015	7	31	16	34	31	0.213	0.036	0.863	0.036	0.033	0	54.2	54.2	67.5	157	156	0	31	30
2015	7	31	16	44	31	0.118	0.085	0.863	0.036	0.033	0	54.6	53.8	67.1	157	155	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	31	16	54	31	0.151	0.023	0.863	0.03	0.03	0	54.2	53.3	67.5	155	153	0	29	29
2015	7	31	17	4	31	0.121	-0.003	0.863	0.039	0.036	0	50.3	49.5	71	147	145	0	30	30
2015	7	31	17	14	31	0.233	-0.016	0.863	0.039	0.036	0	48.2	46.9	71.4	142	138	0	30	29
2015	7	31	17	24	31	0.128	0.056	0.863	0.036	0.033	0	45.6	45.2	72.2	136	135	0	30	30
2015	7	31	17	34	31	0.161	0.072	0.863	0.043	0.039	0	46	46	73.1	138	136	0	31	29
2015	7	31	17	44	31	0.217	-0.02	0.863	0.033	0.03	0	47.3	46.4	72.2	140	138	0	30	30
2015	7	31	17	54	31	0.266	0.003	0.863	0.03	0.03	0	46	46	72.7	138	136	0	31	29
2015	7	31	18	4	31	0.148	-0.059	0.863	0.039	0.036	0	45.2	45.2	73.1	135	134	0	30	29
2015	7	31	18	14	31	0.164	0	0.86	0.036	0.033	0	54.2	51.6	65.4	156	150	0	30	30
2015	7	31	18	24	31	0.148	-0.01	0.863	0.043	0.039	0	49	47.7	70.1	145	141	0	31	30
2015	7	31	18	34	31	0.118	0.013	0.863	0.036	0.033	0	46	44.7	72.7	137	134	0	30	30
2015	7	31	18	44	31	0.19	0.03	0.863	0.039	0.036	0	44.7	43.9	73.5	135	131	0	31	29
2015	7	31	18	54	31	0.167	-0.003	0.86	0.036	0.033	0	52.5	50.3	67.1	152	146	0	30	29
2015	7	31	19	4	31	0.167	-0.023	0.863	0.039	0.039	0	50.7	49.9	67.9	149	145	0	31	29
2015	7	31	19	14	31	0.171	-0.043	0.863	0.039	0.036	0	50.7	49.5	67.9	149	144	0	31	29
2015	7	31	19	24	31	0.22	-0.023	0.863	0.049	0.046	0	50.7	48.6	68.8	148	143	0	30	30
2015	7	31	19	34	31	0.2	-0.082	0.86	0.036	0.033	0	51.6	49.9	67.1	150	145	0	30	29
2015	7	31	19	44	31	0.207	0	0.863	0.039	0.036	0	47.3	46	70.5	141	136	0	31	29
2015	7	31	19	54	31	0.157	-0.069	0.863	0.039	0.036	0	46.9	44.7	72.2	138	134	0	29	30
2015	7	31	20	4	31	0.148	-0.089	0.863	0.033	0.03	0	46	44.7	72.7	138	133	0	31	29
2015	7	31	20	14	31	0.138	0.016	0.863	0.036	0.033	0	46	44.3	72.7	137	133	0	30	30
2015	7	31	20	24	31	0.217	0.003	0.863	0.043	0.039	0	45.2	44.7	72.7	136	133	0	31	29
2015	7	31	20	34	31	0.128	-0.052	0.863	0.033	0.03	0	46	45.2	72.7	137	134	0	30	29
2015	7	31	20	44	31	0.177	-0.026	0.863	0.036	0.033	0	48.2	46.9	70.5	143	139	0	31	30
2015	7	31	20	54	31	0.118	-0.03	0.863	0.043	0.039	0	52	51.2	65.8	152	148	0	31	29
2015	7	31	21	4	31	0.256	0.02	0.863	0.036	0.033	0	46.9	45.2	71.4	139	135	0	30	30
2015	7	31	21	14	31	0.161	0.049	0.863	0.036	0.033	0	46	44.3	72.7	137	132	0	30	29
2015	7	31	21	24	31	0.21	0	0.863	0.036	0.033	0	45.6	44.7	72.7	136	134	0	30	30
2015	7	31	21	34	31	0.23	0.016	0.863	0.033	0.03	0	47.3	45.6	70.5	140	136	0	30	30
2015	7	31	21	44	31	0.167	0.003	0.863	0.036	0.033	0	47.3	46	71.8	140	136	0	30	29
2015	7	31	21	54	31	0.184	0.072	0.863	0.036	0.033	0	45.6	44.3	72.2	136	133	0	30	30
2015	7	31	22	4	31	0.148	0.02	0.863	0.043	0.039	0	44.7	43.9	72.2	134	132	0	30	30
2015	7	31	22	14	31	0.174	-0.036	0.863	0.033	0.03	0	43.9	43.4	74	132	131	0	30	30
2015	7	31	22	24	31	0.187	-0.02	0.863	0.036	0.033	0	45.2	44.3	73.5	136	132	0	31	29

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	31	22	34	31	0.226	0.02	0.863	0.033	0.03	0	44.3	43.4	73.5	133	130	0	30	29
2015	7	31	22	44	31	0.148	-0.016	0.863	0.039	0.036	0	43.4	42.1	74	132	128	0	31	30
2015	7	31	22	54	31	0.144	0.043	0.863	0.033	0.03	0	43.4	42.1	74	132	127	0	31	29
2015	7	31	23	4	31	0.157	0	0.863	0.039	0.039	0	43	43.4	74	131	130	0	31	29
2015	7	31	23	14	31	0.125	-0.102	0.869	0.036	0.033	0	43.9	42.6	67.5	133	129	0	31	30
2015	7	31	23	24	31	0.161	0.02	0.863	0.036	0.033	0	43.9	43	73.5	133	129	0	31	29
2015	7	31	23	34	31	0.125	-0.052	0.863	0.039	0.036	0	44.3	42.6	73.5	133	129	0	30	30
2015	7	31	23	44	31	0.194	-0.066	0.863	0.039	0.036	0	45.2	43.4	72.7	135	131	0	30	30
2015	7	31	23	54	31	0.246	0.039	0.863	0.039	0.036	0	45.2	43.9	73.1	135	132	0	30	30

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	1	0	6	52	30	0	0	0	0	0	0	0	75.97	0	0	12
2015	7	1	0	16	52	30	0	0	0	0	0	0	0	75.85	0	0	12
2015	7	1	0	26	52	30	0	0	0	0	0	0	0	75.72	0	0	12
2015	7	1	0	36	52	31	0	0	0	0	0	0	0	75.6	0	0	12
2015	7	1	0	46	52	30	0	0	0	0	0	0	0	75.49	0	0	12
2015	7	1	0	56	52	31	0	0	0	0	0	0	0	75.36	0	0	12
2015	7	1	1	6	52	31	0	0	0	0	0	0	0	75.25	0	0	12
2015	7	1	1	16	52	30	0	0	0	0	0	0	0	75.15	0	0	12
2015	7	1	1	26	52	31	0	0	0	0	0	0	0	75.04	0	0	12
2015	7	1	1	36	52	30	0	0	0	0	0	0	0	74.93	0	0	12
2015	7	1	1	46	52	30	0	0	0	0	0	0	0	74.84	0	0	12
2015	7	1	1	56	52	31	0	0	0	0	0	0	0	74.75	0	0	12
2015	7	1	2	6	52	31	0	0	0	0	0	0	0	74.64	0	0	12
2015	7	1	2	16	52	30	0	0	0	0	0	0	0	74.53	0	0	12
2015	7	1	2	26	52	31	0	0	0	0	0	0	0	74.44	0	0	12
2015	7	1	2	36	52	31	0	0	0	0	0	0	0	74.34	0	0	12
2015	7	1	2	46	52	31	0	0	0	0	0	0	0	74.23	0	0	12
2015	7	1	2	56	52	30	0	0	0	0	0	0	0	74.14	0	0	12
2015	7	1	3	6	52	31	0	0	0	0	0	0	0	74.03	0	0	12
2015	7	1	3	16	52	31	0	0	0	0	0	0	0	73.94	0	0	12
2015	7	1	3	26	52	31	0	0	0	0	0	0	0	73.83	0	0	12
2015	7	1	3	36	52	30	0	0	0	0	0	0	0	73.72	0	0	12
2015	7	1	3	46	52	30	0	0	0	0	0	0	0	73.62	0	0	12
2015	7	1	3	56	52	31	0	0	0	0	0	0	0	73.51	0	0	12
2015	7	1	4	6	52	30	0	0	0	0	0	0	0	73.42	0	0	12
2015	7	1	4	16	52	30	0	0	0	0	0	0	0	73.31	0	0	12
2015	7	1	4	26	52	30	0	0	0	0	0	0	0	73.24	0	0	12
2015	7	1	4	36	52	30	0	0	0	0	0	0	0	73.15	0	0	12
2015	7	1	4	46	52	30	0	0	0	0	0	0	0	73.06	0	0	12
2015	7	1	4	56	52	30	0	0	0	0	0	0	0	72.99	0	0	12
2015	7	1	5	6	52	30	0	0	0	0	0	0	0	72.9	0	0	12
2015	7	1	5	16	52	30	0	0	0	0	0	0	0	72.84	0	0	12
2015	7	1	5	26	52	31	0	0	0	0	0	0	0	72.77	0	0	12
2015	7	1	5	36	52	31	0	0	0	0	0	0	0	72.7	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	1	5	46	52	31	0	0	0	0	0	0	0	72.63	0	0	12
2015	7	1	5	56	52	30	0	0	0	0	0	0	0	72.55	0	0	12
2015	7	1	6	6	52	31	0	0	0	0	0	0	0	72.46	0	0	12
2015	7	1	6	16	52	30	0	0	0	0	0	0	0	72.39	0	0	12
2015	7	1	6	26	52	30	0	0	0	0	0	0	0	72.32	0	0	12
2015	7	1	6	36	52	31	0	0	0	0	0	0	0	72.23	0	0	12
2015	7	1	6	46	52	31	0	0	0	0	0	0	0	72.16	0	0	12
2015	7	1	6	56	52	31	0	0	0	0	0	0	0	72.12	0	0	12
2015	7	1	7	6	52	31	0	0	0	0	0	0	0	72.1	0	0	12
2015	7	1	7	16	52	31	0	0	0	0	0	0	0	72.05	0	0	12
2015	7	1	7	26	52	30	0	0	0	0	0	0	0	71.98	0	0	12
2015	7	1	7	36	52	31	0	0	0	0	0	0	0	71.94	0	0	12
2015	7	1	7	46	52	30	0	0	0	0	0	0	0	71.91	0	0	12
2015	7	1	7	56	52	31	0	0	0	0	0	0	0	71.85	0	0	12
2015	7	1	8	6	52	31	0	0	0	0	0	0	0	71.82	0	0	12
2015	7	1	8	16	52	31	0	0	0	0	0	0	0	71.74	0	0	12
2015	7	1	8	26	52	31	0	0	0	0	0	0	0	71.73	0	0	12
2015	7	1	8	36	52	30	0	0	0	0	0	0	0	71.67	0	0	12
2015	7	1	8	46	52	30	0	0	0	0	0	0	0	71.64	0	0	12
2015	7	1	8	56	52	31	0	0	0	0	0	0	0	71.58	0	0	12
2015	7	1	9	6	52	32	0	0	0	0	0	0	0	71.56	0	0	12
2015	7	1	9	16	52	31	0	0	0	0	0	0	0	71.62	0	0	12
2015	7	1	9	26	52	31	0	0	0	0	0	0	0	71.6	0	0	12
2015	7	1	9	36	52	31	0	0	0	0	0	0	0	71.51	0	0	12
2015	7	1	9	46	52	31	0	0	0	0	0	0	0	71.44	0	0	12
2015	7	1	9	56	52	30	0	0	0	0	0	0	0	71.37	0	0	12
2015	7	1	10	6	52	31	0	0	0	0	0	0	0	71.38	0	0	12
2015	7	1	10	16	52	31	0	0	0	0	0	0	0	71.51	0	0	12.2
2015	7	1	10	26	52	31	0	0	0	0	0	0	0	71.53	0	0	12.2
2015	7	1	10	36	52	31	0	0	0	0	0	0	0	71.37	0	0	12
2015	7	1	10	46	52	31	0	0	0	0	0	0	0	71.4	0	0	12
2015	7	1	10	56	52	31	0	0	0	0	0	0	0	71.4	0	0	12
2015	7	1	11	6	52	31	0	0	0	0	0	0	0	71.42	0	0	12
2015	7	1	11	16	52	31	0	0	0	0	0	0	0	71.76	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	1	11	26	52	31	0	0	0	0	0	0	0	72.23	0	0	13
2015	7	1	11	36	52	31	0	0	0	0	0	0	0	72.68	0	0	13.2
2015	7	1	11	46	52	31	0	0	0	0	0	0	0	72.27	0	0	13
2015	7	1	11	56	52	31	0	0	0	0	0	0	0	72.23	0	0	13.4
2015	7	1	12	6	52	31	0	0	0	0	0	0	0	72.3	0	0	13.6
2015	7	1	12	16	52	31	0	0	0	0	0	0	0	72.43	0	0	13
2015	7	1	12	26	52	30	0	0	0	0	0	0	0	72.5	0	0	13.4
2015	7	1	12	36	52	31	0	0	0	0	0	0	0	72.63	0	0	13
2015	7	1	12	46	52	31	0	0	0	0	0	0	0	72.77	0	0	13.2
2015	7	1	12	56	52	31	0	0	0	0	0	0	0	72.93	0	0	13.2
2015	7	1	13	6	52	31	0	0	0	0	0	0	0	73.08	0	0	12.8
2015	7	1	13	16	52	31	0	0	0	0	0	0	0	73.27	0	0	13
2015	7	1	13	26	52	31	0	0	0	0	0	0	0	74.43	0	0	13.4
2015	7	1	13	36	52	30	0	0	0	0	0	0	0	74.79	0	0	13.4
2015	7	1	13	46	52	30	0	0	0	0	0	0	0	75.13	0	0	13.4
2015	7	1	13	56	52	30	0	0	0	0	0	0	0	74.93	0	0	13.2
2015	7	1	14	6	52	31	0	0	0	0	0	0	0	75.52	0	0	13.4
2015	7	1	14	16	52	31	0	0	0	0	0	0	0	75.81	0	0	13.2
2015	7	1	14	26	52	30	0	0	0	0	0	0	0	75.97	0	0	13.2
2015	7	1	14	36	52	31	0	0	0	0	0	0	0	75.83	0	0	13.2
2015	7	1	14	46	52	30	0	0	0	0	0	0	0	76.46	0	0	13.2
2015	7	1	14	56	52	30	0	0	0	0	0	0	0	76.48	0	0	13.2
2015	7	1	15	6	52	30	0	0	0	0	0	0	0	76.23	0	0	13
2015	7	1	15	16	52	30	0	0	0	0	0	0	0	76.75	0	0	13.2
2015	7	1	15	26	52	29	0	0	0	0	0	0	0	77.02	0	0	13.2
2015	7	1	15	36	52	30	0	0	0	0	0	0	0	77.13	0	0	13
2015	7	1	15	46	52	30	0	0	0	0	0	0	0	77.29	0	0	13
2015	7	1	15	56	52	31	0	0	0	0	0	0	0	77.45	0	0	13
2015	7	1	16	6	52	31	0	0	0	0	0	0	0	77.47	0	0	13
2015	7	1	16	16	52	30	0	0	0	0	0	0	0	77.54	0	0	12.8
2015	7	1	16	26	52	30	0	0	0	0	0	0	0	77.47	0	0	12.6
2015	7	1	16	36	52	30	0	0	0	0	0	0	0	77.59	0	0	12.6
2015	7	1	16	46	52	30	0	0	0	0	0	0	0	77.63	0	0	12.6
2015	7	1	16	56	52	30	0	0	0	0	0	0	0	77.58	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	1	17	6	52	30	0	0	0	0	0	0	0	77.7	0	0	12.4
2015	7	1	17	16	52	30	0	0	0	0	0	0	0	77.76	0	0	12.4
2015	7	1	17	26	52	30	0	0	0	0	0	0	0	77.79	0	0	12.2
2015	7	1	17	36	52	30	0	0	0	0	0	0	0	77.59	0	0	12.2
2015	7	1	17	46	52	30	0	0	0	0	0	0	0	77.49	0	0	12.2
2015	7	1	17	56	52	30	0	0	0	0	0	0	0	77.47	0	0	12.2
2015	7	1	18	6	52	30	0	0	0	0	0	0	0	77.49	0	0	12.2
2015	7	1	18	16	52	30	0	0	0	0	0	0	0	77.5	0	0	12.2
2015	7	1	18	26	52	30	0	0	0	0	0	0	0	77.56	0	0	12.2
2015	7	1	18	36	52	30	0	0	0	0	0	0	0	77.59	0	0	12.2
2015	7	1	18	46	52	30	0	0	0	0	0	0	0	77.61	0	0	12.2
2015	7	1	18	56	52	30	0	0	0	0	0	0	0	77.63	0	0	12.2
2015	7	1	19	6	52	30	0	0	0	0	0	0	0	77.65	0	0	12.2
2015	7	1	19	16	52	31	0	0	0	0	0	0	0	77.67	0	0	12.2
2015	7	1	19	26	52	30	0	0	0	0	0	0	0	77.68	0	0	12.2
2015	7	1	19	36	52	30	0	0	0	0	0	0	0	77.7	0	0	12.2
2015	7	1	19	46	52	30	0	0	0	0	0	0	0	77.7	0	0	12.2
2015	7	1	19	56	52	30	0	0	0	0	0	0	0	77.7	0	0	12.2
2015	7	1	20	6	52	31	0	0	0	0	0	0	0	77.7	0	0	12.2
2015	7	1	20	16	52	31	0	0	0	0	0	0	0	77.7	0	0	12.2
2015	7	1	20	26	52	30	0	0	0	0	0	0	0	77.7	0	0	12.2
2015	7	1	20	36	52	30	0	0	0	0	0	0	0	77.7	0	0	12.2
2015	7	1	20	46	52	31	0	0	0	0	0	0	0	77.7	0	0	12.2
2015	7	1	20	56	52	30	0	0	0	0	0	0	0	77.7	0	0	12.2
2015	7	1	21	6	52	30	0	0	0	0	0	0	0	77.7	0	0	12
2015	7	1	21	16	52	30	0	0	0	0	0	0	0	77.7	0	0	12
2015	7	1	21	26	52	30	0	0	0	0	0	0	0	77.7	0	0	12
2015	7	1	21	36	52	30	0	0	0	0	0	0	0	77.68	0	0	12
2015	7	1	21	46	52	30	0	0	0	0	0	0	0	77.68	0	0	12
2015	7	1	21	56	52	31	0	0	0	0	0	0	0	77.68	0	0	12
2015	7	1	22	6	52	30	0	0	0	0	0	0	0	77.68	0	0	12
2015	7	1	22	16	52	30	0	0	0	0	0	0	0	77.67	0	0	12
2015	7	1	22	26	52	29	0	0	0	0	0	0	0	77.65	0	0	12
2015	7	1	22	36	52	30	0	0	0	0	0	0	0	77.63	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	1	22	46	52	30	0	0	0	0	0	0	0	77.59	0	0	12
2015	7	1	22	56	52	30	0	0	0	0	0	0	0	77.54	0	0	12
2015	7	1	23	6	52	30	0	0	0	0	0	0	0	77.49	0	0	12
2015	7	1	23	16	52	30	0	0	0	0	0	0	0	77.43	0	0	12
2015	7	1	23	26	52	30	0	0	0	0	0	0	0	77.36	0	0	12
2015	7	1	23	36	52	30	0	0	0	0	0	0	0	77.29	0	0	12
2015	7	1	23	46	52	30	0	0	0	0	0	0	0	77.2	0	0	12
2015	7	1	23	56	52	30	0	0	0	0	0	0	0	77.13	0	0	12
2015	7	2	0	6	52	30	0	0	0	0	0	0	0	77.05	0	0	12
2015	7	2	0	16	52	31	0	0	0	0	0	0	0	76.98	0	0	12
2015	7	2	0	26	52	30	0	0	0	0	0	0	0	76.87	0	0	12
2015	7	2	0	36	52	30	0	0	0	0	0	0	0	76.8	0	0	12
2015	7	2	0	46	52	30	0	0	0	0	0	0	0	76.68	0	0	12
2015	7	2	0	56	52	30	0	0	0	0	0	0	0	76.57	0	0	12
2015	7	2	1	6	52	30	0	0	0	0	0	0	0	76.48	0	0	12
2015	7	2	1	16	52	30	0	0	0	0	0	0	0	76.37	0	0	12
2015	7	2	1	26	52	31	0	0	0	0	0	0	0	76.28	0	0	12
2015	7	2	1	36	52	30	0	0	0	0	0	0	0	76.15	0	0	12
2015	7	2	1	46	52	31	0	0	0	0	0	0	0	76.05	0	0	12
2015	7	2	1	56	52	30	0	0	0	0	0	0	0	75.94	0	0	12
2015	7	2	2	6	52	30	0	0	0	0	0	0	0	75.83	0	0	12
2015	7	2	2	16	52	30	0	0	0	0	0	0	0	75.72	0	0	12
2015	7	2	2	26	52	30	0	0	0	0	0	0	0	75.61	0	0	12
2015	7	2	2	36	52	30	0	0	0	0	0	0	0	75.52	0	0	12
2015	7	2	2	46	52	31	0	0	0	0	0	0	0	75.42	0	0	12
2015	7	2	2	56	52	31	0	0	0	0	0	0	0	75.33	0	0	12
2015	7	2	3	6	52	30	0	0	0	0	0	0	0	75.2	0	0	12
2015	7	2	3	16	52	30	0	0	0	0	0	0	0	75.11	0	0	12
2015	7	2	3	26	52	30	0	0	0	0	0	0	0	75	0	0	12
2015	7	2	3	36	52	31	0	0	0	0	0	0	0	74.89	0	0	12
2015	7	2	3	46	52	30	0	0	0	0	0	0	0	74.79	0	0	12
2015	7	2	3	56	52	30	0	0	0	0	0	0	0	74.68	0	0	12
2015	7	2	4	6	52	31	0	0	0	0	0	0	0	74.57	0	0	12
2015	7	2	4	16	52	30	0	0	0	0	0	0	0	74.44	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	2	4	26	52	31	0	0	0	0	0	0	0	74.34	0	0	12
2015	7	2	4	36	52	30	0	0	0	0	0	0	0	74.21	0	0	12
2015	7	2	4	46	52	30	0	0	0	0	0	0	0	74.14	0	0	12
2015	7	2	4	56	52	30	0	0	0	0	0	0	0	74.03	0	0	12
2015	7	2	5	6	52	30	0	0	0	0	0	0	0	73.92	0	0	12
2015	7	2	5	16	52	31	0	0	0	0	0	0	0	73.83	0	0	12
2015	7	2	5	26	52	31	0	0	0	0	0	0	0	73.74	0	0	12
2015	7	2	5	36	52	31	0	0	0	0	0	0	0	73.67	0	0	12
2015	7	2	5	46	52	31	0	0	0	0	0	0	0	73.58	0	0	12
2015	7	2	5	56	52	31	0	0	0	0	0	0	0	73.51	0	0	12
2015	7	2	6	6	52	30	0	0	0	0	0	0	0	73.47	0	0	12
2015	7	2	6	16	52	30	0	0	0	0	0	0	0	73.42	0	0	12
2015	7	2	6	26	52	30	0	0	0	0	0	0	0	73.38	0	0	12
2015	7	2	6	36	52	30	0	0	0	0	0	0	0	73.35	0	0	12
2015	7	2	6	46	52	31	0	0	0	0	0	0	0	73.29	0	0	12
2015	7	2	6	56	52	30	0	0	0	0	0	0	0	73.29	0	0	12
2015	7	2	7	6	52	31	0	0	0	0	0	0	0	73.24	0	0	12
2015	7	2	7	16	52	31	0	0	0	0	0	0	0	73.33	0	0	12.2
2015	7	2	7	26	52	31	0	0	0	0	0	0	0	73.38	0	0	12.2
2015	7	2	7	36	52	30	0	0	0	0	0	0	0	73.58	0	0	12.4
2015	7	2	7	46	52	30	0	0	0	0	0	0	0	73.98	0	0	12.8
2015	7	2	7	56	52	30	0	0	0	0	0	0	0	74.03	0	0	12.8
2015	7	2	8	6	52	30	0	0	0	0	0	0	0	73.83	0	0	12.8
2015	7	2	8	16	52	31	0	0	0	0	0	0	0	73.83	0	0	12.8
2015	7	2	8	26	52	30	0	0	0	0	0	0	0	74.12	0	0	13
2015	7	2	8	36	52	31	0	0	0	0	0	0	0	74.03	0	0	13
2015	7	2	8	46	52	31	0	0	0	0	0	0	0	74.23	0	0	13
2015	7	2	8	56	52	30	0	0	0	0	0	0	0	74.3	0	0	13
2015	7	2	9	6	52	30	0	0	0	0	0	0	0	73.76	0	0	12.6
2015	7	2	9	16	52	31	0	0	0	0	0	0	0	73.62	0	0	12.6
2015	7	2	9	26	52	30	0	0	0	0	0	0	0	73.71	0	0	12.6
2015	7	2	9	36	52	30	0	0	0	0	0	0	0	73.63	0	0	12.4
2015	7	2	9	46	52	31	0	0	0	0	0	0	0	73.62	0	0	12.6
2015	7	2	9	56	52	31	0	0	0	0	0	0	0	74.48	0	0	13

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	2	10	6	52	31	0	0	0	0	0	0	0	74.61	0	0	13
2015	7	2	10	16	52	30	0	0	0	0	0	0	0	74.23	0	0	12.8
2015	7	2	10	26	52	31	0	0	0	0	0	0	0	74.32	0	0	12.8
2015	7	2	10	36	52	30	0	0	0	0	0	0	0	74.95	0	0	13.2
2015	7	2	10	46	52	30	0	0	0	0	0	0	0	75.09	0	0	12.8
2015	7	2	10	56	52	30	0	0	0	0	0	0	0	74.61	0	0	12.8
2015	7	2	11	6	52	30	0	0	0	0	0	0	0	74.75	0	0	12.8
2015	7	2	11	16	52	31	0	0	0	0	0	0	0	75	0	0	13
2015	7	2	11	26	52	30	0	0	0	0	0	0	0	75	0	0	12.8
2015	7	2	11	36	52	30	0	0	0	0	0	0	0	74.75	0	0	12.6
2015	7	2	11	46	52	30	0	0	0	0	0	0	0	74.8	0	0	12.6
2015	7	2	11	56	52	30	0	0	0	0	0	0	0	75.09	0	0	12.8
2015	7	2	12	6	52	30	0	0	0	0	0	0	0	75.4	0	0	12.8
2015	7	2	12	16	52	30	0	0	0	0	0	0	0	75.22	0	0	12.8
2015	7	2	12	26	52	30	0	0	0	0	0	0	0	75.52	0	0	13
2015	7	2	12	36	52	30	0	0	0	0	0	0	0	75.87	0	0	13.2
2015	7	2	12	46	52	30	0	0	0	0	0	0	0	76.03	0	0	13.4
2015	7	2	12	56	52	30	0	0	0	0	0	0	0	76.12	0	0	13.2
2015	7	2	13	6	52	30	0	0	0	0	0	0	0	76.3	0	0	13
2015	7	2	13	16	52	31	0	0	0	0	0	0	0	76.48	0	0	13
2015	7	2	13	26	52	30	0	0	0	0	0	0	0	76.55	0	0	13
2015	7	2	13	36	52	30	0	0	0	0	0	0	0	77.11	0	0	13.2
2015	7	2	13	46	52	30	0	0	0	0	0	0	0	77.72	0	0	13.2
2015	7	2	13	56	52	30	0	0	0	0	0	0	0	77.58	0	0	13
2015	7	2	14	6	52	31	0	0	0	0	0	0	0	78.01	0	0	13
2015	7	2	14	16	52	30	0	0	0	0	0	0	0	77.72	0	0	12.8
2015	7	2	14	26	52	31	0	0	0	0	0	0	0	78.37	0	0	13
2015	7	2	14	36	52	30	0	0	0	0	0	0	0	78.35	0	0	13.2
2015	7	2	14	46	52	30	0	0	0	0	0	0	0	78.67	0	0	13.2
2015	7	2	14	56	52	30	0	0	0	0	0	0	0	79.02	0	0	13
2015	7	2	15	6	52	30	0	0	0	0	0	0	0	79.48	0	0	13.2
2015	7	2	15	16	52	30	0	0	0	0	0	0	0	79.72	0	0	13.2
2015	7	2	15	26	52	30	0	0	0	0	0	0	0	79.7	0	0	12.8
2015	7	2	15	36	52	30	0	0	0	0	0	0	0	79.39	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	2	15	46	52	30	0	0	0	0	0	0	0	80.06	0	0	13
2015	7	2	15	56	52	30	0	0	0	0	0	0	0	80.28	0	0	12.8
2015	7	2	16	6	52	30	0	0	0	0	0	0	0	80.51	0	0	12.8
2015	7	2	16	16	52	30	0	0	0	0	0	0	0	80.65	0	0	12.8
2015	7	2	16	26	52	30	0	0	0	0	0	0	0	80.76	0	0	12.6
2015	7	2	16	36	52	29	0	0	0	0	0	0	0	80.96	0	0	12.6
2015	7	2	16	46	52	30	0	0	0	0	0	0	0	81.09	0	0	12.6
2015	7	2	16	56	52	30	0	0	0	0	0	0	0	81.21	0	0	12.4
2015	7	2	17	6	52	30	0	0	0	0	0	0	0	81.34	0	0	12.4
2015	7	2	17	16	52	29	0	0	0	0	0	0	0	81.37	0	0	12.4
2015	7	2	17	26	52	30	0	0	0	0	0	0	0	81.43	0	0	12.2
2015	7	2	17	36	52	30	0	0	0	0	0	0	0	81.27	0	0	12.2
2015	7	2	17	46	52	29	0	0	0	0	0	0	0	81.18	0	0	12.2
2015	7	2	17	56	52	30	0	0	0	0	0	0	0	81.19	0	0	12.2
2015	7	2	18	6	52	30	0	0	0	0	0	0	0	81.27	0	0	12.2
2015	7	2	18	16	52	30	0	0	0	0	0	0	0	81.32	0	0	12.2
2015	7	2	18	26	52	30	0	0	0	0	0	0	0	81.41	0	0	12.2
2015	7	2	18	36	52	30	0	0	0	0	0	0	0	81.5	0	0	12.2
2015	7	2	18	46	52	30	0	0	0	0	0	0	0	81.55	0	0	12.2
2015	7	2	18	56	52	30	0	0	0	0	0	0	0	81.61	0	0	12.2
2015	7	2	19	6	52	29	0	0	0	0	0	0	0	81.66	0	0	12.2
2015	7	2	19	16	52	30	0	0	0	0	0	0	0	81.68	0	0	12.2
2015	7	2	19	26	52	29	0	0	0	0	0	0	0	81.7	0	0	12.2
2015	7	2	19	36	52	29	0	0	0	0	0	0	0	81.7	0	0	12.2
2015	7	2	19	46	52	30	0	0	0	0	0	0	0	81.7	0	0	12.2
2015	7	2	19	56	52	30	0	0	0	0	0	0	0	81.68	0	0	12.2
2015	7	2	20	6	52	30	0	0	0	0	0	0	0	81.64	0	0	12.2
2015	7	2	20	16	52	30	0	0	0	0	0	0	0	81.61	0	0	12.2
2015	7	2	20	26	52	30	0	0	0	0	0	0	0	81.57	0	0	12.2
2015	7	2	20	36	52	30	0	0	0	0	0	0	0	81.54	0	0	12.2
2015	7	2	20	46	52	29	0	0	0	0	0	0	0	81.48	0	0	12.2
2015	7	2	20	56	52	29	0	0	0	0	0	0	0	81.43	0	0	12.2
2015	7	2	21	6	52	30	0	0	0	0	0	0	0	81.39	0	0	12
2015	7	2	21	16	52	29	0	0	0	0	0	0	0	81.34	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	2	21	26	52	30	0	0	0	0	0	0	0	81.28	0	0	12
2015	7	2	21	36	52	30	0	0	0	0	0	0	0	81.23	0	0	12
2015	7	2	21	46	52	30	0	0	0	0	0	0	0	81.18	0	0	12
2015	7	2	21	56	52	30	0	0	0	0	0	0	0	81.1	0	0	12
2015	7	2	22	6	52	30	0	0	0	0	0	0	0	81.03	0	0	12
2015	7	2	22	16	52	30	0	0	0	0	0	0	0	80.94	0	0	12
2015	7	2	22	26	52	29	0	0	0	0	0	0	0	80.85	0	0	12
2015	7	2	22	36	52	30	0	0	0	0	0	0	0	80.73	0	0	12
2015	7	2	22	46	52	30	0	0	0	0	0	0	0	80.6	0	0	12
2015	7	2	22	56	52	30	0	0	0	0	0	0	0	80.47	0	0	12
2015	7	2	23	6	52	30	0	0	0	0	0	0	0	80.31	0	0	12
2015	7	2	23	16	52	30	0	0	0	0	0	0	0	80.19	0	0	12
2015	7	2	23	26	52	30	0	0	0	0	0	0	0	80.02	0	0	12
2015	7	2	23	36	52	30	0	0	0	0	0	0	0	79.86	0	0	12
2015	7	2	23	46	52	29	0	0	0	0	0	0	0	79.7	0	0	12
2015	7	2	23	56	52	30	0	0	0	0	0	0	0	79.54	0	0	12
2015	7	3	0	6	52	30	0	0	0	0	0	0	0	79.38	0	0	12
2015	7	3	0	16	52	30	0	0	0	0	0	0	0	79.23	0	0	12
2015	7	3	0	26	52	30	0	0	0	0	0	0	0	79.07	0	0	12
2015	7	3	0	36	52	30	0	0	0	0	0	0	0	78.93	0	0	12
2015	7	3	0	46	52	30	0	0	0	0	0	0	0	78.78	0	0	12
2015	7	3	0	56	52	30	0	0	0	0	0	0	0	78.66	0	0	12
2015	7	3	1	6	52	30	0	0	0	0	0	0	0	78.51	0	0	12
2015	7	3	1	16	52	29	0	0	0	0	0	0	0	78.37	0	0	12
2015	7	3	1	26	52	30	0	0	0	0	0	0	0	78.24	0	0	12
2015	7	3	1	36	52	30	0	0	0	0	0	0	0	78.12	0	0	12
2015	7	3	1	46	52	31	0	0	0	0	0	0	0	77.95	0	0	12
2015	7	3	1	56	52	30	0	0	0	0	0	0	0	77.79	0	0	12
2015	7	3	2	6	52	30	0	0	0	0	0	0	0	77.68	0	0	12
2015	7	3	2	16	52	30	0	0	0	0	0	0	0	77.56	0	0	12
2015	7	3	2	26	52	30	0	0	0	0	0	0	0	77.4	0	0	12
2015	7	3	2	36	52	30	0	0	0	0	0	0	0	77.29	0	0	12
2015	7	3	2	46	52	30	0	0	0	0	0	0	0	77.16	0	0	12
2015	7	3	2	56	52	30	0	0	0	0	0	0	0	77.05	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	3	3	6	52	30	0	0	0	0	0	0	0	76.95	0	0	12
2015	7	3	3	16	52	30	0	0	0	0	0	0	0	76.86	0	0	12
2015	7	3	3	26	52	30	0	0	0	0	0	0	0	76.77	0	0	12
2015	7	3	3	36	52	30	0	0	0	0	0	0	0	76.68	0	0	12
2015	7	3	3	46	52	30	0	0	0	0	0	0	0	76.59	0	0	12
2015	7	3	3	56	52	30	0	0	0	0	0	0	0	76.5	0	0	12
2015	7	3	4	6	52	30	0	0	0	0	0	0	0	76.41	0	0	12
2015	7	3	4	16	52	30	0	0	0	0	0	0	0	76.3	0	0	12
2015	7	3	4	26	52	30	0	0	0	0	0	0	0	76.23	0	0	12
2015	7	3	4	36	52	30	0	0	0	0	0	0	0	76.12	0	0	12
2015	7	3	4	46	52	31	0	0	0	0	0	0	0	76.03	0	0	12
2015	7	3	4	56	52	30	0	0	0	0	0	0	0	75.9	0	0	12
2015	7	3	5	6	52	30	0	0	0	0	0	0	0	75.81	0	0	12
2015	7	3	5	16	52	31	0	0	0	0	0	0	0	75.69	0	0	12
2015	7	3	5	26	52	30	0	0	0	0	0	0	0	75.56	0	0	12
2015	7	3	5	36	52	30	0	0	0	0	0	0	0	75.47	0	0	12
2015	7	3	5	46	52	31	0	0	0	0	0	0	0	75.36	0	0	12
2015	7	3	5	56	52	30	0	0	0	0	0	0	0	75.25	0	0	12
2015	7	3	6	6	52	30	0	0	0	0	0	0	0	75.18	0	0	12
2015	7	3	6	16	52	30	0	0	0	0	0	0	0	75.11	0	0	12
2015	7	3	6	26	52	30	0	0	0	0	0	0	0	75.02	0	0	12
2015	7	3	6	36	52	31	0	0	0	0	0	0	0	74.93	0	0	12
2015	7	3	6	46	52	31	0	0	0	0	0	0	0	74.91	0	0	12
2015	7	3	6	56	52	30	0	0	0	0	0	0	0	75.02	0	0	12.2
2015	7	3	7	6	52	30	0	0	0	0	0	0	0	75.04	0	0	12.2
2015	7	3	7	16	52	30	0	0	0	0	0	0	0	75.11	0	0	12.4
2015	7	3	7	26	52	30	0	0	0	0	0	0	0	75.2	0	0	12.6
2015	7	3	7	36	52	30	0	0	0	0	0	0	0	75.25	0	0	12.6
2015	7	3	7	46	52	31	0	0	0	0	0	0	0	75.4	0	0	12.8
2015	7	3	7	56	52	30	0	0	0	0	0	0	0	75.54	0	0	12.8
2015	7	3	8	6	52	30	0	0	0	0	0	0	0	75.61	0	0	13
2015	7	3	8	16	52	30	0	0	0	0	0	0	0	75.67	0	0	13
2015	7	3	8	26	52	31	0	0	0	0	0	0	0	75.76	0	0	13
2015	7	3	8	36	52	31	0	0	0	0	0	0	0	75.88	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	3	8	46	52	31	0	0	0	0	0	0	0	75.9	0	0	13
2015	7	3	8	56	52	31	0	0	0	0	0	0	0	76.15	0	0	13.2
2015	7	3	9	6	52	30	0	0	0	0	0	0	0	76.24	0	0	13.2
2015	7	3	9	16	52	31	0	0	0	0	0	0	0	76.21	0	0	13.2
2015	7	3	9	26	52	31	0	0	0	0	0	0	0	76.28	0	0	13.2
2015	7	3	9	36	52	31	0	0	0	0	0	0	0	76.41	0	0	13.2
2015	7	3	9	46	52	30	0	0	0	0	0	0	0	76.53	0	0	13.4
2015	7	3	9	56	52	30	0	0	0	0	0	0	0	76.69	0	0	13.4
2015	7	3	10	6	52	30	0	0	0	0	0	0	0	76.91	0	0	13.4
2015	7	3	10	16	52	31	0	0	0	0	0	0	0	77.16	0	0	13.4
2015	7	3	10	26	52	30	0	0	0	0	0	0	0	77.36	0	0	13.4
2015	7	3	10	36	52	30	0	0	0	0	0	0	0	77.5	0	0	13.4
2015	7	3	10	46	52	30	0	0	0	0	0	0	0	77.52	0	0	13.2
2015	7	3	10	56	52	30	0	0	0	0	0	0	0	77.83	0	0	13.4
2015	7	3	11	6	52	30	0	0	0	0	0	0	0	78.03	0	0	13.2
2015	7	3	11	16	52	30	0	0	0	0	0	0	0	78.33	0	0	13.4
2015	7	3	11	26	52	30	0	0	0	0	0	0	0	78.58	0	0	13.2
2015	7	3	11	36	52	30	0	0	0	0	0	0	0	78.71	0	0	13.2
2015	7	3	11	46	52	31	0	0	0	0	0	0	0	78.98	0	0	13.2
2015	7	3	11	56	52	30	0	0	0	0	0	0	0	77.83	0	0	13.2
2015	7	3	12	6	52	30	0	0	0	0	0	0	0	77.61	0	0	13.2
2015	7	3	12	16	52	29	0	0	0	0	0	0	0	77.68	0	0	13.2
2015	7	3	12	26	52	30	0	0	0	0	0	0	0	77.92	0	0	13.2
2015	7	3	12	36	52	30	0	0	0	0	0	0	0	78.13	0	0	13.2
2015	7	3	12	46	52	30	0	0	0	0	0	0	0	78.4	0	0	13.2
2015	7	3	12	56	52	30	0	0	0	0	0	0	0	78.69	0	0	13.2
2015	7	3	13	6	52	30	0	0	0	0	0	0	0	79.02	0	0	13.2
2015	7	3	13	16	52	29	0	0	0	0	0	0	0	79.56	0	0	13.2
2015	7	3	13	26	52	30	0	0	0	0	0	0	0	81.01	0	0	13.2
2015	7	3	13	36	52	30	0	0	0	0	0	0	0	81.52	0	0	13.2
2015	7	3	13	46	52	29	0	0	0	0	0	0	0	82.04	0	0	13.2
2015	7	3	13	56	52	30	0	0	0	0	0	0	0	82.18	0	0	13.2
2015	7	3	14	6	52	29	0	0	0	0	0	0	0	82.35	0	0	13.2
2015	7	3	14	16	52	30	0	0	0	0	0	0	0	82.78	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	3	14	26	52	30	0	0	0	0	0	0	0	82.87	0	0	13.2
2015	7	3	14	36	52	29	0	0	0	0	0	0	0	83.1	0	0	13.2
2015	7	3	14	46	52	30	0	0	0	0	0	0	0	83.19	0	0	13.2
2015	7	3	14	56	52	29	0	0	0	0	0	0	0	83.01	0	0	13
2015	7	3	15	6	52	30	0	0	0	0	0	0	0	83.39	0	0	13.2
2015	7	3	15	16	52	30	0	0	0	0	0	0	0	83.53	0	0	13.2
2015	7	3	15	26	52	30	0	0	0	0	0	0	0	84	0	0	13.2
2015	7	3	15	36	52	29	0	0	0	0	0	0	0	84.09	0	0	13
2015	7	3	15	46	52	29	0	0	0	0	0	0	0	84.07	0	0	13
2015	7	3	15	56	52	30	0	0	0	0	0	0	0	84.13	0	0	13
2015	7	3	16	6	52	30	0	0	0	0	0	0	0	84.2	0	0	12.8
2015	7	3	16	16	52	29	0	0	0	0	0	0	0	84.16	0	0	12.8
2015	7	3	16	26	52	29	0	0	0	0	0	0	0	84.07	0	0	12.6
2015	7	3	16	36	52	30	0	0	0	0	0	0	0	84.04	0	0	12.6
2015	7	3	16	46	52	29	0	0	0	0	0	0	0	84.06	0	0	12.6
2015	7	3	16	56	52	30	0	0	0	0	0	0	0	84.06	0	0	12.6
2015	7	3	17	6	52	30	0	0	0	0	0	0	0	84.06	0	0	12.4
2015	7	3	17	16	52	30	0	0	0	0	0	0	0	84.02	0	0	12.4
2015	7	3	17	26	52	29	0	0	0	0	0	0	0	84.11	0	0	12.4
2015	7	3	17	36	52	29	0	0	0	0	0	0	0	84.11	0	0	12.4
2015	7	3	17	46	52	29	0	0	0	0	0	0	0	84.11	0	0	12.4
2015	7	3	17	56	52	29	0	0	0	0	0	0	0	84.07	0	0	12.4
2015	7	3	18	6	52	30	0	0	0	0	0	0	0	84.06	0	0	12.4
2015	7	3	18	16	52	30	0	0	0	0	0	0	0	83.98	0	0	12.2
2015	7	3	18	26	52	29	0	0	0	0	0	0	0	83.93	0	0	12.2
2015	7	3	18	36	52	29	0	0	0	0	0	0	0	83.89	0	0	12.2
2015	7	3	18	46	52	29	0	0	0	0	0	0	0	83.86	0	0	12.2
2015	7	3	18	56	52	29	0	0	0	0	0	0	0	83.82	0	0	12.2
2015	7	3	19	6	52	29	0	0	0	0	0	0	0	83.77	0	0	12.2
2015	7	3	19	16	52	30	0	0	0	0	0	0	0	83.73	0	0	12.2
2015	7	3	19	26	52	29	0	0	0	0	0	0	0	83.71	0	0	12.2
2015	7	3	19	36	52	29	0	0	0	0	0	0	0	83.68	0	0	12.2
2015	7	3	19	46	52	30	0	0	0	0	0	0	0	83.64	0	0	12.2
2015	7	3	19	56	52	30	0	0	0	0	0	0	0	83.59	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	3	20	6	52	30	0	0	0	0	0	0	0	83.53	0	0	12.2
2015	7	3	20	16	52	30	0	0	0	0	0	0	0	83.46	0	0	12.2
2015	7	3	20	26	52	29	0	0	0	0	0	0	0	83.37	0	0	12.2
2015	7	3	20	36	52	30	0	0	0	0	0	0	0	83.28	0	0	12.2
2015	7	3	20	46	52	30	0	0	0	0	0	0	0	83.19	0	0	12.2
2015	7	3	20	56	52	29	0	0	0	0	0	0	0	83.08	0	0	12.2
2015	7	3	21	6	52	30	0	0	0	0	0	0	0	82.96	0	0	12.2
2015	7	3	21	16	52	30	0	0	0	0	0	0	0	82.83	0	0	12.2
2015	7	3	21	26	52	29	0	0	0	0	0	0	0	82.69	0	0	12.2
2015	7	3	21	36	52	29	0	0	0	0	0	0	0	82.53	0	0	12.2
2015	7	3	21	46	52	29	0	0	0	0	0	0	0	82.38	0	0	12.2
2015	7	3	21	56	52	29	0	0	0	0	0	0	0	82.2	0	0	12.2
2015	7	3	22	6	52	30	0	0	0	0	0	0	0	82.02	0	0	12
2015	7	3	22	16	52	29	0	0	0	0	0	0	0	81.82	0	0	12
2015	7	3	22	26	52	29	0	0	0	0	0	0	0	81.64	0	0	12
2015	7	3	22	36	52	29	0	0	0	0	0	0	0	81.45	0	0	12
2015	7	3	22	46	52	29	0	0	0	0	0	0	0	81.25	0	0	12
2015	7	3	22	56	52	29	0	0	0	0	0	0	0	81.05	0	0	12
2015	7	3	23	6	52	30	0	0	0	0	0	0	0	80.85	0	0	12
2015	7	3	23	16	52	30	0	0	0	0	0	0	0	80.65	0	0	12
2015	7	3	23	26	52	30	0	0	0	0	0	0	0	80.46	0	0	12
2015	7	3	23	36	52	30	0	0	0	0	0	0	0	80.24	0	0	12
2015	7	3	23	46	52	30	0	0	0	0	0	0	0	80.02	0	0	12
2015	7	3	23	56	52	30	0	0	0	0	0	0	0	79.81	0	0	12
2015	7	4	0	6	52	30	0	0	0	0	0	0	0	79.61	0	0	12
2015	7	4	0	16	52	29	0	0	0	0	0	0	0	79.43	0	0	12
2015	7	4	0	26	52	30	0	0	0	0	0	0	0	79.21	0	0	12
2015	7	4	0	36	52	30	0	0	0	0	0	0	0	79	0	0	12
2015	7	4	0	46	52	30	0	0	0	0	0	0	0	78.82	0	0	12
2015	7	4	0	56	52	30	0	0	0	0	0	0	0	78.6	0	0	12
2015	7	4	1	6	52	30	0	0	0	0	0	0	0	78.4	0	0	12
2015	7	4	1	16	52	30	0	0	0	0	0	0	0	78.22	0	0	12
2015	7	4	1	26	52	30	0	0	0	0	0	0	0	78.04	0	0	12
2015	7	4	1	36	52	30	0	0	0	0	0	0	0	77.86	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	4	1	46	52	30	0	0	0	0	0	0	0	77.7	0	0	12
2015	7	4	1	56	52	30	0	0	0	0	0	0	0	77.54	0	0	12
2015	7	4	2	6	52	30	0	0	0	0	0	0	0	77.36	0	0	12
2015	7	4	2	16	52	30	0	0	0	0	0	0	0	77.2	0	0	12
2015	7	4	2	26	52	30	0	0	0	0	0	0	0	77.04	0	0	12
2015	7	4	2	36	52	29	0	0	0	0	0	0	0	76.87	0	0	12
2015	7	4	2	46	52	30	0	0	0	0	0	0	0	76.71	0	0	12
2015	7	4	2	56	52	30	0	0	0	0	0	0	0	76.59	0	0	12
2015	7	4	3	6	52	30	0	0	0	0	0	0	0	76.46	0	0	12
2015	7	4	3	16	52	30	0	0	0	0	0	0	0	76.35	0	0	12
2015	7	4	3	26	52	30	0	0	0	0	0	0	0	76.21	0	0	12
2015	7	4	3	36	52	30	0	0	0	0	0	0	0	76.1	0	0	12
2015	7	4	3	46	52	30	0	0	0	0	0	0	0	76.01	0	0	12
2015	7	4	3	56	52	30	0	0	0	0	0	0	0	75.92	0	0	12
2015	7	4	4	6	52	31	0	0	0	0	0	0	0	75.81	0	0	12
2015	7	4	4	16	52	30	0	0	0	0	0	0	0	75.69	0	0	12
2015	7	4	4	26	52	30	0	0	0	0	0	0	0	75.58	0	0	12
2015	7	4	4	36	52	30	0	0	0	0	0	0	0	75.49	0	0	12
2015	7	4	4	46	52	30	0	0	0	0	0	0	0	75.42	0	0	12
2015	7	4	4	56	52	31	0	0	0	0	0	0	0	75.33	0	0	12
2015	7	4	5	6	52	31	0	0	0	0	0	0	0	75.27	0	0	12
2015	7	4	5	16	52	31	0	0	0	0	0	0	0	75.18	0	0	12
2015	7	4	5	26	52	31	0	0	0	0	0	0	0	75.11	0	0	12
2015	7	4	5	36	52	30	0	0	0	0	0	0	0	75.06	0	0	12
2015	7	4	5	46	52	31	0	0	0	0	0	0	0	74.98	0	0	12
2015	7	4	5	56	52	31	0	0	0	0	0	0	0	74.95	0	0	12
2015	7	4	6	6	52	31	0	0	0	0	0	0	0	74.88	0	0	12
2015	7	4	6	16	52	30	0	0	0	0	0	0	0	74.82	0	0	12
2015	7	4	6	26	52	30	0	0	0	0	0	0	0	74.79	0	0	12
2015	7	4	6	36	52	30	0	0	0	0	0	0	0	74.73	0	0	12
2015	7	4	6	46	52	30	0	0	0	0	0	0	0	74.73	0	0	12
2015	7	4	6	56	52	30	0	0	0	0	0	0	0	74.71	0	0	12
2015	7	4	7	6	52	31	0	0	0	0	0	0	0	74.66	0	0	12
2015	7	4	7	16	52	32	0	0	0	0	0	0	0	74.62	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	4	7	26	52	30	0	0	0	0	0	0	0	74.57	0	0	12
2015	7	4	7	36	52	30	0	0	0	0	0	0	0	74.57	0	0	12
2015	7	4	7	46	52	30	0	0	0	0	0	0	0	74.55	0	0	12
2015	7	4	7	56	52	31	0	0	0	0	0	0	0	74.57	0	0	12
2015	7	4	8	6	52	30	0	0	0	0	0	0	0	74.66	0	0	12.2
2015	7	4	8	16	52	30	0	0	0	0	0	0	0	74.57	0	0	12
2015	7	4	8	26	52	31	0	0	0	0	0	0	0	74.52	0	0	12
2015	7	4	8	36	52	31	0	0	0	0	0	0	0	74.55	0	0	12.2
2015	7	4	8	46	52	30	0	0	0	0	0	0	0	74.57	0	0	12.2
2015	7	4	8	56	52	30	0	0	0	0	0	0	0	74.55	0	0	12.2
2015	7	4	9	6	52	30	0	0	0	0	0	0	0	74.55	0	0	12.2
2015	7	4	9	16	52	30	0	0	0	0	0	0	0	74.53	0	0	12.2
2015	7	4	9	26	52	31	0	0	0	0	0	0	0	74.43	0	0	12
2015	7	4	9	36	52	31	0	0	0	0	0	0	0	74.39	0	0	12
2015	7	4	9	46	52	30	0	0	0	0	0	0	0	74.44	0	0	12.2
2015	7	4	9	56	52	31	0	0	0	0	0	0	0	74.5	0	0	12.2
2015	7	4	10	6	52	30	0	0	0	0	0	0	0	74.71	0	0	12.4
2015	7	4	10	16	52	31	0	0	0	0	0	0	0	75.18	0	0	12.8
2015	7	4	10	26	52	30	0	0	0	0	0	0	0	75.4	0	0	13
2015	7	4	10	36	52	30	0	0	0	0	0	0	0	75.43	0	0	13
2015	7	4	10	46	52	31	0	0	0	0	0	0	0	75.38	0	0	13
2015	7	4	10	56	52	31	0	0	0	0	0	0	0	75.7	0	0	13
2015	7	4	11	6	52	31	0	0	0	0	0	0	0	75.88	0	0	13.2
2015	7	4	11	16	52	30	0	0	0	0	0	0	0	75.58	0	0	12.8
2015	7	4	11	26	52	30	0	0	0	0	0	0	0	76.08	0	0	13.2
2015	7	4	11	36	52	30	0	0	0	0	0	0	0	76.24	0	0	13.2
2015	7	4	11	46	52	30	0	0	0	0	0	0	0	76.26	0	0	13
2015	7	4	11	56	52	30	0	0	0	0	0	0	0	75.87	0	0	12.8
2015	7	4	12	6	52	30	0	0	0	0	0	0	0	76.12	0	0	13.2
2015	7	4	12	16	52	30	0	0	0	0	0	0	0	76.32	0	0	13.2
2015	7	4	12	26	52	31	0	0	0	0	0	0	0	76.42	0	0	13.2
2015	7	4	12	36	52	30	0	0	0	0	0	0	0	76.55	0	0	13.2
2015	7	4	12	46	52	31	0	0	0	0	0	0	0	76.86	0	0	13.2
2015	7	4	12	56	52	30	0	0	0	0	0	0	0	77.2	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	4	13	6	52	30	0	0	0	0	0	0	0	77.36	0	0	13.2
2015	7	4	13	16	52	30	0	0	0	0	0	0	0	77.63	0	0	13.2
2015	7	4	13	26	52	31	0	0	0	0	0	0	0	78.62	0	0	13.2
2015	7	4	13	36	52	30	0	0	0	0	0	0	0	79.11	0	0	13.2
2015	7	4	13	46	52	30	0	0	0	0	0	0	0	79.47	0	0	13.2
2015	7	4	13	56	52	30	0	0	0	0	0	0	0	79.83	0	0	13.2
2015	7	4	14	6	52	30	0	0	0	0	0	0	0	80.33	0	0	13.2
2015	7	4	14	16	52	30	0	0	0	0	0	0	0	80.22	0	0	13
2015	7	4	14	26	52	30	0	0	0	0	0	0	0	80.8	0	0	13.2
2015	7	4	14	36	52	30	0	0	0	0	0	0	0	80.98	0	0	13.2
2015	7	4	14	46	52	30	0	0	0	0	0	0	0	81.03	0	0	13.2
2015	7	4	14	56	52	30	0	0	0	0	0	0	0	80.51	0	0	12.8
2015	7	4	15	6	52	30	0	0	0	0	0	0	0	81.12	0	0	12.8
2015	7	4	15	16	52	30	0	0	0	0	0	0	0	80.76	0	0	12.6
2015	7	4	15	26	52	30	0	0	0	0	0	0	0	80.71	0	0	12.6
2015	7	4	15	36	52	30	0	0	0	0	0	0	0	80.8	0	0	12.6
2015	7	4	15	46	52	29	0	0	0	0	0	0	0	80.91	0	0	12.6
2015	7	4	15	56	52	30	0	0	0	0	0	0	0	81.16	0	0	12.6
2015	7	4	16	6	52	29	0	0	0	0	0	0	0	81	0	0	12.4
2015	7	4	16	16	52	30	0	0	0	0	0	0	0	80.89	0	0	12.2
2015	7	4	16	26	52	30	0	0	0	0	0	0	0	80.73	0	0	12.2
2015	7	4	16	36	52	29	0	0	0	0	0	0	0	80.64	0	0	12.2
2015	7	4	16	46	52	30	0	0	0	0	0	0	0	80.53	0	0	12.2
2015	7	4	16	56	52	30	0	0	0	0	0	0	0	80.44	0	0	12.2
2015	7	4	17	6	52	30	0	0	0	0	0	0	0	80.37	0	0	12.2
2015	7	4	17	16	52	30	0	0	0	0	0	0	0	80.33	0	0	12.2
2015	7	4	17	26	52	30	0	0	0	0	0	0	0	80.31	0	0	12.2
2015	7	4	17	36	52	30	0	0	0	0	0	0	0	80.2	0	0	12.2
2015	7	4	17	46	52	30	0	0	0	0	0	0	0	80.17	0	0	12.2
2015	7	4	17	56	52	30	0	0	0	0	0	0	0	80.06	0	0	12.2
2015	7	4	18	6	52	29	0	0	0	0	0	0	0	79.93	0	0	12.2
2015	7	4	18	16	52	30	0	0	0	0	0	0	0	79.9	0	0	12.2
2015	7	4	18	26	52	30	0	0	0	0	0	0	0	79.86	0	0	12.2
2015	7	4	18	36	52	29	0	0	0	0	0	0	0	79.83	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	4	18	46	52	30	0	0	0	0	0	0	0	79.79	0	0	12.2
2015	7	4	18	56	52	30	0	0	0	0	0	0	0	79.75	0	0	12.2
2015	7	4	19	6	52	29	0	0	0	0	0	0	0	79.68	0	0	12.2
2015	7	4	19	16	52	30	0	0	0	0	0	0	0	79.63	0	0	12
2015	7	4	19	26	52	30	0	0	0	0	0	0	0	79.56	0	0	12
2015	7	4	19	36	52	30	0	0	0	0	0	0	0	79.48	0	0	12
2015	7	4	19	46	52	31	0	0	0	0	0	0	0	79.41	0	0	12
2015	7	4	19	56	52	30	0	0	0	0	0	0	0	79.38	0	0	12
2015	7	4	20	6	52	30	0	0	0	0	0	0	0	79.32	0	0	12
2015	7	4	20	16	52	30	0	0	0	0	0	0	0	79.27	0	0	12
2015	7	4	20	26	52	30	0	0	0	0	0	0	0	79.2	0	0	12
2015	7	4	20	36	52	31	0	0	0	0	0	0	0	79.11	0	0	12
2015	7	4	20	46	52	29	0	0	0	0	0	0	0	79.02	0	0	12
2015	7	4	20	56	52	30	0	0	0	0	0	0	0	78.93	0	0	12
2015	7	4	21	6	52	30	0	0	0	0	0	0	0	78.84	0	0	12
2015	7	4	21	16	52	30	0	0	0	0	0	0	0	78.75	0	0	12
2015	7	4	21	26	52	30	0	0	0	0	0	0	0	78.66	0	0	12
2015	7	4	21	36	52	29	0	0	0	0	0	0	0	78.57	0	0	12
2015	7	4	21	46	52	30	0	0	0	0	0	0	0	78.49	0	0	12
2015	7	4	21	56	52	30	0	0	0	0	0	0	0	78.37	0	0	12
2015	7	4	22	6	52	30	0	0	0	0	0	0	0	78.24	0	0	12
2015	7	4	22	16	52	30	0	0	0	0	0	0	0	78.1	0	0	12
2015	7	4	22	26	52	30	0	0	0	0	0	0	0	77.94	0	0	12
2015	7	4	22	36	52	30	0	0	0	0	0	0	0	77.77	0	0	12
2015	7	4	22	46	52	30	0	0	0	0	0	0	0	77.61	0	0	12
2015	7	4	22	56	52	30	0	0	0	0	0	0	0	77.45	0	0	12
2015	7	4	23	6	52	30	0	0	0	0	0	0	0	77.27	0	0	12
2015	7	4	23	16	52	31	0	0	0	0	0	0	0	77.09	0	0	12
2015	7	4	23	26	52	30	0	0	0	0	0	0	0	76.91	0	0	12
2015	7	4	23	36	52	30	0	0	0	0	0	0	0	76.73	0	0	12
2015	7	4	23	46	52	30	0	0	0	0	0	0	0	76.55	0	0	12
2015	7	4	23	56	52	31	0	0	0	0	0	0	0	76.39	0	0	12
2015	7	5	0	6	52	29	0	0	0	0	0	0	0	76.21	0	0	12
2015	7	5	0	16	52	31	0	0	0	0	0	0	0	76.05	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	5	0	26	52	30	0	0	0	0	0	0	0	75.88	0	0	12
2015	7	5	0	36	52	30	0	0	0	0	0	0	0	75.72	0	0	12
2015	7	5	0	46	52	30	0	0	0	0	0	0	0	75.56	0	0	12
2015	7	5	0	56	52	30	0	0	0	0	0	0	0	75.38	0	0	12
2015	7	5	1	6	52	30	0	0	0	0	0	0	0	75.2	0	0	12
2015	7	5	1	16	52	30	0	0	0	0	0	0	0	75.02	0	0	12
2015	7	5	1	26	52	30	0	0	0	0	0	0	0	74.86	0	0	12
2015	7	5	1	36	52	31	0	0	0	0	0	0	0	74.68	0	0	12
2015	7	5	1	46	52	30	0	0	0	0	0	0	0	74.48	0	0	12
2015	7	5	1	56	52	31	0	0	0	0	0	0	0	74.3	0	0	12
2015	7	5	2	6	52	30	0	0	0	0	0	0	0	74.12	0	0	12
2015	7	5	2	16	52	31	0	0	0	0	0	0	0	73.94	0	0	12
2015	7	5	2	26	52	30	0	0	0	0	0	0	0	73.74	0	0	12
2015	7	5	2	36	52	31	0	0	0	0	0	0	0	73.54	0	0	12
2015	7	5	2	46	52	31	0	0	0	0	0	0	0	73.35	0	0	12
2015	7	5	2	56	52	31	0	0	0	0	0	0	0	73.17	0	0	12
2015	7	5	3	6	52	31	0	0	0	0	0	0	0	72.99	0	0	12
2015	7	5	3	16	52	31	0	0	0	0	0	0	0	72.81	0	0	12
2015	7	5	3	26	52	31	0	0	0	0	0	0	0	72.63	0	0	12
2015	7	5	3	36	52	30	0	0	0	0	0	0	0	72.45	0	0	12
2015	7	5	3	46	52	30	0	0	0	0	0	0	0	72.28	0	0	11.8
2015	7	5	3	56	52	31	0	0	0	0	0	0	0	72.12	0	0	11.8
2015	7	5	4	6	52	31	0	0	0	0	0	0	0	71.96	0	0	11.8
2015	7	5	4	16	52	31	0	0	0	0	0	0	0	71.78	0	0	11.8
2015	7	5	4	26	52	30	0	0	0	0	0	0	0	71.6	0	0	11.8
2015	7	5	4	36	52	30	0	0	0	0	0	0	0	71.44	0	0	11.8
2015	7	5	4	46	52	31	0	0	0	0	0	0	0	71.29	0	0	11.8
2015	7	5	4	56	52	31	0	0	0	0	0	0	0	71.15	0	0	11.8
2015	7	5	5	6	52	31	0	0	0	0	0	0	0	71.01	0	0	11.8
2015	7	5	5	16	52	31	0	0	0	0	0	0	0	70.88	0	0	11.8
2015	7	5	5	26	52	31	0	0	0	0	0	0	0	70.75	0	0	11.8
2015	7	5	5	36	52	30	0	0	0	0	0	0	0	70.65	0	0	11.8
2015	7	5	5	46	52	31	0	0	0	0	0	0	0	70.56	0	0	11.8
2015	7	5	5	56	52	30	0	0	0	0	0	0	0	70.45	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	5	6	6	52	30	0	0	0	0	0	0	0	70.36	0	0	11.8
2015	7	5	6	16	52	31	0	0	0	0	0	0	0	70.27	0	0	11.8
2015	7	5	6	26	52	31	0	0	0	0	0	0	0	70.2	0	0	11.8
2015	7	5	6	36	52	31	0	0	0	0	0	0	0	70.12	0	0	11.8
2015	7	5	6	46	52	31	0	0	0	0	0	0	0	70.09	0	0	12
2015	7	5	6	56	52	31	0	0	0	0	0	0	0	70.27	0	0	12.2
2015	7	5	7	6	52	31	0	0	0	0	0	0	0	70.34	0	0	12.2
2015	7	5	7	16	52	32	0	0	0	0	0	0	0	70.41	0	0	12.4
2015	7	5	7	26	52	31	0	0	0	0	0	0	0	70.5	0	0	12.6
2015	7	5	7	36	52	31	0	0	0	0	0	0	0	70.65	0	0	12.6
2015	7	5	7	46	52	31	0	0	0	0	0	0	0	70.83	0	0	12.8
2015	7	5	7	56	52	31	0	0	0	0	0	0	0	70.92	0	0	12.8
2015	7	5	8	6	52	32	0	0	0	0	0	0	0	71.08	0	0	13
2015	7	5	8	16	52	31	0	0	0	0	0	0	0	71.22	0	0	13
2015	7	5	8	26	52	31	0	0	0	0	0	0	0	71.35	0	0	13
2015	7	5	8	36	52	31	0	0	0	0	0	0	0	71.46	0	0	13.2
2015	7	5	8	46	52	31	0	0	0	0	0	0	0	71.58	0	0	13.2
2015	7	5	8	56	52	31	0	0	0	0	0	0	0	71.76	0	0	13.2
2015	7	5	9	6	52	30	0	0	0	0	0	0	0	71.87	0	0	13.2
2015	7	5	9	16	52	30	0	0	0	0	0	0	0	72.03	0	0	13.2
2015	7	5	9	26	52	31	0	0	0	0	0	0	0	72.23	0	0	13.2
2015	7	5	9	36	52	31	0	0	0	0	0	0	0	72.39	0	0	13.2
2015	7	5	9	46	52	31	0	0	0	0	0	0	0	72.54	0	0	13.2
2015	7	5	9	56	52	31	0	0	0	0	0	0	0	72.72	0	0	13.2
2015	7	5	10	6	52	30	0	0	0	0	0	0	0	72.84	0	0	13.2
2015	7	5	10	16	52	31	0	0	0	0	0	0	0	73.04	0	0	13.2
2015	7	5	10	26	52	31	0	0	0	0	0	0	0	73.15	0	0	13.2
2015	7	5	10	36	52	30	0	0	0	0	0	0	0	73.36	0	0	13.2
2015	7	5	10	46	52	30	0	0	0	0	0	0	0	73.6	0	0	13.2
2015	7	5	10	56	52	31	0	0	0	0	0	0	0	73.72	0	0	13.2
2015	7	5	11	6	52	31	0	0	0	0	0	0	0	73.89	0	0	13.2
2015	7	5	11	16	52	31	0	0	0	0	0	0	0	74.19	0	0	13.2
2015	7	5	11	26	52	30	0	0	0	0	0	0	0	74.43	0	0	13.2
2015	7	5	11	36	52	31	0	0	0	0	0	0	0	74.64	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	5	11	46	52	31	0	0	0	0	0	0	0	74.89	0	0	13.2
2015	7	5	11	56	52	31	0	0	0	0	0	0	0	73.94	0	0	13.2
2015	7	5	12	6	52	31	0	0	0	0	0	0	0	73.87	0	0	13.2
2015	7	5	12	16	52	30	0	0	0	0	0	0	0	74.03	0	0	13.2
2015	7	5	12	26	52	31	0	0	0	0	0	0	0	74.28	0	0	13.2
2015	7	5	12	36	52	30	0	0	0	0	0	0	0	74.57	0	0	13.2
2015	7	5	12	46	52	30	0	0	0	0	0	0	0	74.86	0	0	13.2
2015	7	5	12	56	52	31	0	0	0	0	0	0	0	75.16	0	0	13.2
2015	7	5	13	6	52	31	0	0	0	0	0	0	0	75.52	0	0	13.2
2015	7	5	13	16	52	30	0	0	0	0	0	0	0	76.03	0	0	13.2
2015	7	5	13	26	52	30	0	0	0	0	0	0	0	77.31	0	0	13.2
2015	7	5	13	36	52	30	0	0	0	0	0	0	0	77.23	0	0	12.6
2015	7	5	13	46	52	31	0	0	0	0	0	0	0	76.95	0	0	12.4
2015	7	5	13	56	52	30	0	0	0	0	0	0	0	77.04	0	0	12.4
2015	7	5	14	6	52	31	0	0	0	0	0	0	0	77.14	0	0	12.4
2015	7	5	14	16	52	30	0	0	0	0	0	0	0	77.2	0	0	12.2
2015	7	5	14	26	52	30	0	0	0	0	0	0	0	77.23	0	0	12.2
2015	7	5	14	36	52	30	0	0	0	0	0	0	0	77.23	0	0	12.2
2015	7	5	14	46	52	30	0	0	0	0	0	0	0	77.25	0	0	12.2
2015	7	5	14	56	52	30	0	0	0	0	0	0	0	77.27	0	0	12.2
2015	7	5	15	6	52	30	0	0	0	0	0	0	0	77.23	0	0	12.2
2015	7	5	15	16	52	30	0	0	0	0	0	0	0	77.18	0	0	12.2
2015	7	5	15	26	52	30	0	0	0	0	0	0	0	77.11	0	0	12.2
2015	7	5	15	36	52	30	0	0	0	0	0	0	0	77.04	0	0	12.2
2015	7	5	15	46	52	30	0	0	0	0	0	0	0	77.04	0	0	12.2
2015	7	5	15	56	52	31	0	0	0	0	0	0	0	77.05	0	0	12.2
2015	7	5	16	6	52	31	0	0	0	0	0	0	0	77.09	0	0	12.2
2015	7	5	16	16	52	30	0	0	0	0	0	0	0	77.13	0	0	12.4
2015	7	5	16	26	52	31	0	0	0	0	0	0	0	77.22	0	0	12.4
2015	7	5	16	36	52	30	0	0	0	0	0	0	0	77.36	0	0	12.4
2015	7	5	16	46	52	30	0	0	0	0	0	0	0	77.68	0	0	12.6
2015	7	5	16	56	52	30	0	0	0	0	0	0	0	77.94	0	0	12.6
2015	7	5	17	6	52	30	0	0	0	0	0	0	0	77.81	0	0	12.4
2015	7	5	17	16	52	30	0	0	0	0	0	0	0	77.92	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	5	17	26	52	30	0	0	0	0	0	0	0	78.03	0	0	12.4
2015	7	5	17	36	52	31	0	0	0	0	0	0	0	77.99	0	0	12.4
2015	7	5	17	46	52	30	0	0	0	0	0	0	0	77.88	0	0	12.4
2015	7	5	17	56	52	30	0	0	0	0	0	0	0	77.92	0	0	12.4
2015	7	5	18	6	52	30	0	0	0	0	0	0	0	77.99	0	0	12.4
2015	7	5	18	16	52	30	0	0	0	0	0	0	0	78.04	0	0	12.4
2015	7	5	18	26	52	30	0	0	0	0	0	0	0	78.08	0	0	12.4
2015	7	5	18	36	52	30	0	0	0	0	0	0	0	78.08	0	0	12.2
2015	7	5	18	46	52	30	0	0	0	0	0	0	0	77.99	0	0	12.2
2015	7	5	18	56	52	30	0	0	0	0	0	0	0	77.92	0	0	12.2
2015	7	5	19	6	52	30	0	0	0	0	0	0	0	77.85	0	0	12.2
2015	7	5	19	16	52	30	0	0	0	0	0	0	0	77.76	0	0	12.2
2015	7	5	19	26	52	30	0	0	0	0	0	0	0	77.72	0	0	12.2
2015	7	5	19	36	52	30	0	0	0	0	0	0	0	77.61	0	0	12.2
2015	7	5	19	46	52	30	0	0	0	0	0	0	0	77.49	0	0	12.2
2015	7	5	19	56	52	30	0	0	0	0	0	0	0	77.38	0	0	12.2
2015	7	5	20	6	52	30	0	0	0	0	0	0	0	77.27	0	0	12.2
2015	7	5	20	16	52	30	0	0	0	0	0	0	0	77.14	0	0	12.2
2015	7	5	20	26	52	30	0	0	0	0	0	0	0	77.04	0	0	12
2015	7	5	20	36	52	30	0	0	0	0	0	0	0	76.93	0	0	12
2015	7	5	20	46	52	30	0	0	0	0	0	0	0	76.82	0	0	12
2015	7	5	20	56	52	30	0	0	0	0	0	0	0	76.69	0	0	12
2015	7	5	21	6	52	29	0	0	0	0	0	0	0	76.6	0	0	12
2015	7	5	21	16	52	30	0	0	0	0	0	0	0	76.5	0	0	12
2015	7	5	21	26	52	30	0	0	0	0	0	0	0	76.39	0	0	12
2015	7	5	21	36	52	31	0	0	0	0	0	0	0	76.28	0	0	12
2015	7	5	21	46	52	30	0	0	0	0	0	0	0	76.15	0	0	12
2015	7	5	21	56	52	30	0	0	0	0	0	0	0	76.01	0	0	12
2015	7	5	22	6	52	30	0	0	0	0	0	0	0	75.9	0	0	12
2015	7	5	22	16	52	31	0	0	0	0	0	0	0	75.78	0	0	12
2015	7	5	22	26	52	30	0	0	0	0	0	0	0	75.63	0	0	12
2015	7	5	22	36	52	30	0	0	0	0	0	0	0	75.51	0	0	12
2015	7	5	22	46	52	30	0	0	0	0	0	0	0	75.34	0	0	12
2015	7	5	22	56	52	30	0	0	0	0	0	0	0	75.18	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	5	23	6	52	30	0	0	0	0	0	0	0	75	0	0	12
2015	7	5	23	16	52	31	0	0	0	0	0	0	0	74.82	0	0	12
2015	7	5	23	26	52	31	0	0	0	0	0	0	0	74.64	0	0	12
2015	7	5	23	36	52	31	0	0	0	0	0	0	0	74.48	0	0	12
2015	7	5	23	46	52	30	0	0	0	0	0	0	0	74.3	0	0	12
2015	7	5	23	56	52	30	0	0	0	0	0	0	0	74.14	0	0	12
2015	7	6	0	6	52	30	0	0	0	0	0	0	0	73.96	0	0	12
2015	7	6	0	16	52	31	0	0	0	0	0	0	0	73.8	0	0	12
2015	7	6	0	26	52	31	0	0	0	0	0	0	0	73.62	0	0	12
2015	7	6	0	36	52	30	0	0	0	0	0	0	0	73.47	0	0	12
2015	7	6	0	46	52	30	0	0	0	0	0	0	0	73.33	0	0	12
2015	7	6	0	56	52	30	0	0	0	0	0	0	0	73.17	0	0	12
2015	7	6	1	6	52	30	0	0	0	0	0	0	0	73.04	0	0	12
2015	7	6	1	16	52	30	0	0	0	0	0	0	0	72.91	0	0	12
2015	7	6	1	26	52	31	0	0	0	0	0	0	0	72.79	0	0	12
2015	7	6	1	36	52	30	0	0	0	0	0	0	0	72.66	0	0	12
2015	7	6	1	46	52	30	0	0	0	0	0	0	0	72.54	0	0	12
2015	7	6	1	56	52	30	0	0	0	0	0	0	0	72.41	0	0	12
2015	7	6	2	6	52	31	0	0	0	0	0	0	0	72.28	0	0	12
2015	7	6	2	16	52	31	0	0	0	0	0	0	0	72.18	0	0	12
2015	7	6	2	26	52	30	0	0	0	0	0	0	0	72.07	0	0	12
2015	7	6	2	36	52	31	0	0	0	0	0	0	0	71.94	0	0	12
2015	7	6	2	46	52	31	0	0	0	0	0	0	0	71.8	0	0	12
2015	7	6	2	56	52	31	0	0	0	0	0	0	0	71.69	0	0	12
2015	7	6	3	6	52	30	0	0	0	0	0	0	0	71.58	0	0	12
2015	7	6	3	16	52	31	0	0	0	0	0	0	0	71.46	0	0	12
2015	7	6	3	26	52	31	0	0	0	0	0	0	0	71.33	0	0	12
2015	7	6	3	36	52	32	0	0	0	0	0	0	0	71.22	0	0	12
2015	7	6	3	46	52	31	0	0	0	0	0	0	0	71.1	0	0	12
2015	7	6	3	56	52	31	0	0	0	0	0	0	0	70.97	0	0	12
2015	7	6	4	6	52	31	0	0	0	0	0	0	0	70.84	0	0	12
2015	7	6	4	16	52	30	0	0	0	0	0	0	0	70.74	0	0	11.8
2015	7	6	4	26	52	31	0	0	0	0	0	0	0	70.63	0	0	11.8
2015	7	6	4	36	52	31	0	0	0	0	0	0	0	70.52	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	6	4	46	52	31	0	0	0	0	0	0	0	70.43	0	0	11.8
2015	7	6	4	56	52	30	0	0	0	0	0	0	0	70.32	0	0	11.8
2015	7	6	5	6	52	31	0	0	0	0	0	0	0	70.23	0	0	11.8
2015	7	6	5	16	52	31	0	0	0	0	0	0	0	70.12	0	0	11.8
2015	7	6	5	26	52	31	0	0	0	0	0	0	0	70.03	0	0	11.8
2015	7	6	5	36	52	30	0	0	0	0	0	0	0	69.96	0	0	11.8
2015	7	6	5	46	52	32	0	0	0	0	0	0	0	69.87	0	0	11.8
2015	7	6	5	56	52	31	0	0	0	0	0	0	0	69.78	0	0	11.8
2015	7	6	6	6	52	31	0	0	0	0	0	0	0	69.71	0	0	11.8
2015	7	6	6	16	52	31	0	0	0	0	0	0	0	69.64	0	0	11.8
2015	7	6	6	26	52	31	0	0	0	0	0	0	0	69.58	0	0	11.8
2015	7	6	6	36	52	31	0	0	0	0	0	0	0	69.53	0	0	11.8
2015	7	6	6	46	52	31	0	0	0	0	0	0	0	69.49	0	0	12
2015	7	6	6	56	52	31	0	0	0	0	0	0	0	69.71	0	0	12.2
2015	7	6	7	6	52	31	0	0	0	0	0	0	0	69.78	0	0	12.2
2015	7	6	7	16	52	31	0	0	0	0	0	0	0	69.87	0	0	12.4
2015	7	6	7	26	52	31	0	0	0	0	0	0	0	69.89	0	0	12.6
2015	7	6	7	36	52	32	0	0	0	0	0	0	0	70	0	0	12.6
2015	7	6	7	46	52	31	0	0	0	0	0	0	0	70.05	0	0	12.8
2015	7	6	7	56	52	31	0	0	0	0	0	0	0	70.2	0	0	12.8
2015	7	6	8	6	52	30	0	0	0	0	0	0	0	70.32	0	0	13
2015	7	6	8	16	52	31	0	0	0	0	0	0	0	70.43	0	0	13
2015	7	6	8	26	52	31	0	0	0	0	0	0	0	70.5	0	0	13
2015	7	6	8	36	52	31	0	0	0	0	0	0	0	70.66	0	0	13.2
2015	7	6	8	46	52	31	0	0	0	0	0	0	0	70.83	0	0	13.2
2015	7	6	8	56	52	31	0	0	0	0	0	0	0	71.01	0	0	13.2
2015	7	6	9	6	52	31	0	0	0	0	0	0	0	71.13	0	0	13.2
2015	7	6	9	16	52	30	0	0	0	0	0	0	0	71.26	0	0	13.2
2015	7	6	9	26	52	31	0	0	0	0	0	0	0	71.46	0	0	13.2
2015	7	6	9	36	52	31	0	0	0	0	0	0	0	71.53	0	0	13.2
2015	7	6	9	46	52	30	0	0	0	0	0	0	0	71.69	0	0	13.2
2015	7	6	9	56	52	31	0	0	0	0	0	0	0	71.85	0	0	13.2
2015	7	6	10	6	52	30	0	0	0	0	0	0	0	71.56	0	0	13.2
2015	7	6	10	16	52	32	0	0	0	0	0	0	0	71.69	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	6	10	26	52	31	0	0	0	0	0	0	0	71.89	0	0	13.2
2015	7	6	10	36	52	31	0	0	0	0	0	0	0	72.09	0	0	13.2
2015	7	6	10	46	52	31	0	0	0	0	0	0	0	72.27	0	0	13.2
2015	7	6	10	56	52	30	0	0	0	0	0	0	0	72.39	0	0	13.2
2015	7	6	11	6	52	31	0	0	0	0	0	0	0	72.59	0	0	13.2
2015	7	6	11	16	52	30	0	0	0	0	0	0	0	72.84	0	0	13.2
2015	7	6	11	26	52	31	0	0	0	0	0	0	0	73.06	0	0	13.2
2015	7	6	11	36	52	31	0	0	0	0	0	0	0	73.27	0	0	13.2
2015	7	6	11	46	52	31	0	0	0	0	0	0	0	73.51	0	0	13.2
2015	7	6	11	56	52	31	0	0	0	0	0	0	0	72.81	0	0	13.2
2015	7	6	12	6	52	31	0	0	0	0	0	0	0	72.84	0	0	13.2
2015	7	6	12	16	52	30	0	0	0	0	0	0	0	73.06	0	0	13.2
2015	7	6	12	26	52	31	0	0	0	0	0	0	0	73.33	0	0	13.2
2015	7	6	12	36	52	30	0	0	0	0	0	0	0	73.63	0	0	13.2
2015	7	6	12	46	52	31	0	0	0	0	0	0	0	73.94	0	0	13.2
2015	7	6	12	56	52	30	0	0	0	0	0	0	0	74.26	0	0	13.2
2015	7	6	13	6	52	31	0	0	0	0	0	0	0	74.62	0	0	13.2
2015	7	6	13	16	52	30	0	0	0	0	0	0	0	75.15	0	0	13.2
2015	7	6	13	26	52	31	0	0	0	0	0	0	0	76.24	0	0	13.2
2015	7	6	13	36	52	30	0	0	0	0	0	0	0	76.64	0	0	13.2
2015	7	6	13	46	52	30	0	0	0	0	0	0	0	77.09	0	0	13.2
2015	7	6	13	56	52	31	0	0	0	0	0	0	0	77.38	0	0	13.2
2015	7	6	14	6	52	30	0	0	0	0	0	0	0	77.7	0	0	13.2
2015	7	6	14	16	52	31	0	0	0	0	0	0	0	77.86	0	0	13.2
2015	7	6	14	26	52	30	0	0	0	0	0	0	0	77.99	0	0	13.2
2015	7	6	14	36	52	30	0	0	0	0	0	0	0	78.51	0	0	13.2
2015	7	6	14	46	52	30	0	0	0	0	0	0	0	78.64	0	0	13.2
2015	7	6	14	56	52	31	0	0	0	0	0	0	0	78.51	0	0	12.8
2015	7	6	15	6	52	30	0	0	0	0	0	0	0	78.37	0	0	12.6
2015	7	6	15	16	52	30	0	0	0	0	0	0	0	78.48	0	0	12.6
2015	7	6	15	26	52	31	0	0	0	0	0	0	0	78.58	0	0	12.6
2015	7	6	15	36	52	30	0	0	0	0	0	0	0	78.67	0	0	12.4
2015	7	6	15	46	52	30	0	0	0	0	0	0	0	78.73	0	0	12.4
2015	7	6	15	56	52	30	0	0	0	0	0	0	0	78.82	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	6	16	6	52	30	0	0	0	0	0	0	0	79.2	0	0	12.8
2015	7	6	16	16	52	30	0	0	0	0	0	0	0	79.14	0	0	12.6
2015	7	6	16	26	52	30	0	0	0	0	0	0	0	79.52	0	0	12.8
2015	7	6	16	36	52	30	0	0	0	0	0	0	0	79.68	0	0	12.8
2015	7	6	16	46	52	29	0	0	0	0	0	0	0	79.63	0	0	12.6
2015	7	6	16	56	52	30	0	0	0	0	0	0	0	79.56	0	0	12.4
2015	7	6	17	6	52	30	0	0	0	0	0	0	0	79.48	0	0	12.4
2015	7	6	17	16	52	30	0	0	0	0	0	0	0	79.48	0	0	12.4
2015	7	6	17	26	52	30	0	0	0	0	0	0	0	79.5	0	0	12.2
2015	7	6	17	36	52	30	0	0	0	0	0	0	0	79.5	0	0	12.2
2015	7	6	17	46	52	30	0	0	0	0	0	0	0	79.56	0	0	12.2
2015	7	6	17	56	52	30	0	0	0	0	0	0	0	79.59	0	0	12.2
2015	7	6	18	6	52	30	0	0	0	0	0	0	0	79.61	0	0	12.2
2015	7	6	18	16	52	30	0	0	0	0	0	0	0	79.61	0	0	12.2
2015	7	6	18	26	52	30	0	0	0	0	0	0	0	79.59	0	0	12.2
2015	7	6	18	36	52	30	0	0	0	0	0	0	0	79.57	0	0	12.2
2015	7	6	18	46	52	30	0	0	0	0	0	0	0	79.57	0	0	12.2
2015	7	6	18	56	52	30	0	0	0	0	0	0	0	79.56	0	0	12.2
2015	7	6	19	6	52	30	0	0	0	0	0	0	0	79.54	0	0	12.2
2015	7	6	19	16	52	30	0	0	0	0	0	0	0	79.52	0	0	12.2
2015	7	6	19	26	52	30	0	0	0	0	0	0	0	79.5	0	0	12.2
2015	7	6	19	36	52	30	0	0	0	0	0	0	0	79.47	0	0	12.2
2015	7	6	19	46	52	29	0	0	0	0	0	0	0	79.39	0	0	12.2
2015	7	6	19	56	52	30	0	0	0	0	0	0	0	79.3	0	0	12.2
2015	7	6	20	6	52	30	0	0	0	0	0	0	0	79.18	0	0	12.2
2015	7	6	20	16	52	30	0	0	0	0	0	0	0	79.03	0	0	12.2
2015	7	6	20	26	52	29	0	0	0	0	0	0	0	78.93	0	0	12.2
2015	7	6	20	36	52	29	0	0	0	0	0	0	0	78.8	0	0	12.2
2015	7	6	20	46	52	29	0	0	0	0	0	0	0	78.69	0	0	12.2
2015	7	6	20	56	52	30	0	0	0	0	0	0	0	78.57	0	0	12.2
2015	7	6	21	6	52	30	0	0	0	0	0	0	0	78.46	0	0	12
2015	7	6	21	16	52	30	0	0	0	0	0	0	0	78.35	0	0	12
2015	7	6	21	26	52	29	0	0	0	0	0	0	0	78.21	0	0	12
2015	7	6	21	36	52	30	0	0	0	0	0	0	0	78.1	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	6	21	46	52	30	0	0	0	0	0	0	0	78.01	0	0	12
2015	7	6	21	56	52	30	0	0	0	0	0	0	0	77.9	0	0	12
2015	7	6	22	6	52	30	0	0	0	0	0	0	0	77.79	0	0	12
2015	7	6	22	16	52	30	0	0	0	0	0	0	0	77.67	0	0	12
2015	7	6	22	26	52	30	0	0	0	0	0	0	0	77.5	0	0	12
2015	7	6	22	36	52	30	0	0	0	0	0	0	0	77.32	0	0	12
2015	7	6	22	46	52	31	0	0	0	0	0	0	0	77.14	0	0	12
2015	7	6	22	56	52	31	0	0	0	0	0	0	0	76.96	0	0	12
2015	7	6	23	6	52	30	0	0	0	0	0	0	0	76.77	0	0	12
2015	7	6	23	16	52	30	0	0	0	0	0	0	0	76.59	0	0	12
2015	7	6	23	26	52	30	0	0	0	0	0	0	0	76.39	0	0	12
2015	7	6	23	36	52	30	0	0	0	0	0	0	0	76.21	0	0	12
2015	7	6	23	46	52	31	0	0	0	0	0	0	0	76.01	0	0	12
2015	7	6	23	56	52	30	0	0	0	0	0	0	0	75.83	0	0	12
2015	7	7	0	6	52	30	0	0	0	0	0	0	0	75.69	0	0	12
2015	7	7	0	16	52	30	0	0	0	0	0	0	0	75.52	0	0	12
2015	7	7	0	26	52	31	0	0	0	0	0	0	0	75.4	0	0	12
2015	7	7	0	36	52	30	0	0	0	0	0	0	0	75.24	0	0	12
2015	7	7	0	46	52	30	0	0	0	0	0	0	0	75.11	0	0	12
2015	7	7	0	56	52	30	0	0	0	0	0	0	0	74.95	0	0	12
2015	7	7	1	6	52	31	0	0	0	0	0	0	0	74.8	0	0	12
2015	7	7	1	16	52	30	0	0	0	0	0	0	0	74.66	0	0	12
2015	7	7	1	26	52	30	0	0	0	0	0	0	0	74.52	0	0	12
2015	7	7	1	36	52	30	0	0	0	0	0	0	0	74.39	0	0	12
2015	7	7	1	46	52	30	0	0	0	0	0	0	0	74.28	0	0	12
2015	7	7	1	56	52	31	0	0	0	0	0	0	0	74.14	0	0	12
2015	7	7	2	6	52	30	0	0	0	0	0	0	0	74.01	0	0	12
2015	7	7	2	16	52	30	0	0	0	0	0	0	0	73.85	0	0	12
2015	7	7	2	26	52	30	0	0	0	0	0	0	0	73.74	0	0	12
2015	7	7	2	36	52	30	0	0	0	0	0	0	0	73.62	0	0	12
2015	7	7	2	46	52	30	0	0	0	0	0	0	0	73.49	0	0	12
2015	7	7	2	56	52	31	0	0	0	0	0	0	0	73.36	0	0	12
2015	7	7	3	6	52	31	0	0	0	0	0	0	0	73.24	0	0	12
2015	7	7	3	16	52	30	0	0	0	0	0	0	0	73.15	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	7	3	26	52	31	0	0	0	0	0	0	0	73.04	0	0	12
2015	7	7	3	36	52	31	0	0	0	0	0	0	0	72.93	0	0	12
2015	7	7	3	46	52	30	0	0	0	0	0	0	0	72.82	0	0	12
2015	7	7	3	56	52	31	0	0	0	0	0	0	0	72.72	0	0	12
2015	7	7	4	6	52	30	0	0	0	0	0	0	0	72.61	0	0	12
2015	7	7	4	16	52	30	0	0	0	0	0	0	0	72.5	0	0	12
2015	7	7	4	26	52	32	0	0	0	0	0	0	0	72.41	0	0	12
2015	7	7	4	36	52	30	0	0	0	0	0	0	0	72.3	0	0	12
2015	7	7	4	46	52	31	0	0	0	0	0	0	0	72.21	0	0	12
2015	7	7	4	56	52	31	0	0	0	0	0	0	0	72.12	0	0	12
2015	7	7	5	6	52	31	0	0	0	0	0	0	0	72.03	0	0	12
2015	7	7	5	16	52	31	0	0	0	0	0	0	0	71.94	0	0	12
2015	7	7	5	26	52	31	0	0	0	0	0	0	0	71.89	0	0	12
2015	7	7	5	36	52	31	0	0	0	0	0	0	0	71.8	0	0	12
2015	7	7	5	46	52	31	0	0	0	0	0	0	0	71.73	0	0	12
2015	7	7	5	56	52	31	0	0	0	0	0	0	0	71.65	0	0	12
2015	7	7	6	6	52	31	0	0	0	0	0	0	0	71.58	0	0	12
2015	7	7	6	16	52	30	0	0	0	0	0	0	0	71.53	0	0	12
2015	7	7	6	26	52	31	0	0	0	0	0	0	0	71.46	0	0	12
2015	7	7	6	36	52	31	0	0	0	0	0	0	0	71.38	0	0	12
2015	7	7	6	46	52	30	0	0	0	0	0	0	0	71.35	0	0	12
2015	7	7	6	56	52	30	0	0	0	0	0	0	0	71.53	0	0	12.2
2015	7	7	7	6	52	31	0	0	0	0	0	0	0	71.58	0	0	12.2
2015	7	7	7	16	52	31	0	0	0	0	0	0	0	71.65	0	0	12.4
2015	7	7	7	26	52	31	0	0	0	0	0	0	0	71.71	0	0	12.6
2015	7	7	7	36	52	31	0	0	0	0	0	0	0	71.78	0	0	12.6
2015	7	7	7	46	52	31	0	0	0	0	0	0	0	71.85	0	0	12.8
2015	7	7	7	56	52	31	0	0	0	0	0	0	0	71.94	0	0	12.8
2015	7	7	8	6	52	31	0	0	0	0	0	0	0	72	0	0	13
2015	7	7	8	16	52	31	0	0	0	0	0	0	0	72.09	0	0	13
2015	7	7	8	26	52	31	0	0	0	0	0	0	0	72.21	0	0	13
2015	7	7	8	36	52	31	0	0	0	0	0	0	0	72.32	0	0	13
2015	7	7	8	46	52	31	0	0	0	0	0	0	0	72.39	0	0	13.2
2015	7	7	8	56	52	31	0	0	0	0	0	0	0	72.52	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	7	9	6	52	31	0	0	0	0	0	0	0	72.64	0	0	13.2
2015	7	7	9	16	52	31	0	0	0	0	0	0	0	72.77	0	0	13.2
2015	7	7	9	26	52	31	0	0	0	0	0	0	0	72.88	0	0	13.2
2015	7	7	9	36	52	31	0	0	0	0	0	0	0	73.02	0	0	13.2
2015	7	7	9	46	52	31	0	0	0	0	0	0	0	73.2	0	0	13.2
2015	7	7	9	56	52	31	0	0	0	0	0	0	0	73.33	0	0	13.2
2015	7	7	10	6	52	30	0	0	0	0	0	0	0	73.44	0	0	13.2
2015	7	7	10	16	52	30	0	0	0	0	0	0	0	73.54	0	0	13.2
2015	7	7	10	26	52	31	0	0	0	0	0	0	0	73.76	0	0	13.2
2015	7	7	10	36	52	30	0	0	0	0	0	0	0	73.83	0	0	13.2
2015	7	7	10	46	52	30	0	0	0	0	0	0	0	74.07	0	0	13.2
2015	7	7	10	56	52	30	0	0	0	0	0	0	0	74.17	0	0	13.2
2015	7	7	11	6	52	31	0	0	0	0	0	0	0	74.37	0	0	13.2
2015	7	7	11	16	52	30	0	0	0	0	0	0	0	74.57	0	0	13.2
2015	7	7	11	26	52	31	0	0	0	0	0	0	0	74.71	0	0	13.2
2015	7	7	11	36	52	31	0	0	0	0	0	0	0	74.97	0	0	13.2
2015	7	7	11	46	52	30	0	0	0	0	0	0	0	75.07	0	0	13.2
2015	7	7	11	56	52	30	0	0	0	0	0	0	0	74.14	0	0	13.2
2015	7	7	12	6	52	30	0	0	0	0	0	0	0	74.08	0	0	13.2
2015	7	7	12	16	52	31	0	0	0	0	0	0	0	74.25	0	0	13.2
2015	7	7	12	26	52	30	0	0	0	0	0	0	0	74.44	0	0	13.2
2015	7	7	12	36	52	31	0	0	0	0	0	0	0	74.66	0	0	13.2
2015	7	7	12	46	52	31	0	0	0	0	0	0	0	74.91	0	0	13.2
2015	7	7	12	56	52	31	0	0	0	0	0	0	0	75.2	0	0	13.2
2015	7	7	13	6	52	30	0	0	0	0	0	0	0	75.47	0	0	13.2
2015	7	7	13	16	52	31	0	0	0	0	0	0	0	75.99	0	0	13.2
2015	7	7	13	26	52	30	0	0	0	0	0	0	0	77.07	0	0	13.2
2015	7	7	13	36	52	30	0	0	0	0	0	0	0	77.49	0	0	13.2
2015	7	7	13	46	52	31	0	0	0	0	0	0	0	77.83	0	0	13.4
2015	7	7	13	56	52	30	0	0	0	0	0	0	0	78.06	0	0	13.4
2015	7	7	14	6	52	31	0	0	0	0	0	0	0	78.31	0	0	13.4
2015	7	7	14	16	52	30	0	0	0	0	0	0	0	78.53	0	0	13.2
2015	7	7	14	26	52	30	0	0	0	0	0	0	0	78.75	0	0	13.2
2015	7	7	14	36	52	30	0	0	0	0	0	0	0	78.85	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	7	14	46	52	29	0	0	0	0	0	0	0	79.03	0	0	13.2
2015	7	7	14	56	52	30	0	0	0	0	0	0	0	79.18	0	0	13.2
2015	7	7	15	6	52	30	0	0	0	0	0	0	0	79.3	0	0	13.2
2015	7	7	15	16	52	30	0	0	0	0	0	0	0	79.39	0	0	13.2
2015	7	7	15	26	52	30	0	0	0	0	0	0	0	79.5	0	0	13.2
2015	7	7	15	36	52	31	0	0	0	0	0	0	0	79.59	0	0	13
2015	7	7	15	46	52	30	0	0	0	0	0	0	0	79.66	0	0	13
2015	7	7	15	56	52	30	0	0	0	0	0	0	0	79.74	0	0	13
2015	7	7	16	6	52	30	0	0	0	0	0	0	0	79.83	0	0	12.8
2015	7	7	16	16	52	29	0	0	0	0	0	0	0	79.88	0	0	12.8
2015	7	7	16	26	52	30	0	0	0	0	0	0	0	79.93	0	0	12.8
2015	7	7	16	36	52	30	0	0	0	0	0	0	0	79.93	0	0	12.6
2015	7	7	16	46	52	30	0	0	0	0	0	0	0	79.93	0	0	12.6
2015	7	7	16	56	52	30	0	0	0	0	0	0	0	79.99	0	0	12.4
2015	7	7	17	6	52	30	0	0	0	0	0	0	0	79.97	0	0	12.4
2015	7	7	17	16	52	30	0	0	0	0	0	0	0	79.97	0	0	12.4
2015	7	7	17	26	52	29	0	0	0	0	0	0	0	79.99	0	0	12.2
2015	7	7	17	36	52	30	0	0	0	0	0	0	0	79.79	0	0	12.2
2015	7	7	17	46	52	30	0	0	0	0	0	0	0	79.66	0	0	12.2
2015	7	7	17	56	52	30	0	0	0	0	0	0	0	79.59	0	0	12.2
2015	7	7	18	6	52	30	0	0	0	0	0	0	0	79.52	0	0	12.2
2015	7	7	18	16	52	31	0	0	0	0	0	0	0	79.48	0	0	12.2
2015	7	7	18	26	52	30	0	0	0	0	0	0	0	79.45	0	0	12.2
2015	7	7	18	36	52	30	0	0	0	0	0	0	0	79.48	0	0	12.2
2015	7	7	18	46	52	30	0	0	0	0	0	0	0	79.39	0	0	12.2
2015	7	7	18	56	52	30	0	0	0	0	0	0	0	79.29	0	0	12.2
2015	7	7	19	6	52	30	0	0	0	0	0	0	0	79.2	0	0	12.2
2015	7	7	19	16	52	30	0	0	0	0	0	0	0	79.07	0	0	12.2
2015	7	7	19	26	52	30	0	0	0	0	0	0	0	79	0	0	12.2
2015	7	7	19	36	52	30	0	0	0	0	0	0	0	78.87	0	0	12.2
2015	7	7	19	46	52	30	0	0	0	0	0	0	0	78.73	0	0	12.2
2015	7	7	19	56	52	30	0	0	0	0	0	0	0	78.6	0	0	12.2
2015	7	7	20	6	52	30	0	0	0	0	0	0	0	78.44	0	0	12.2
2015	7	7	20	16	52	30	0	0	0	0	0	0	0	78.28	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	7	20	26	52	30	0	0	0	0	0	0	0	78.13	0	0	12.2
2015	7	7	20	36	52	30	0	0	0	0	0	0	0	77.97	0	0	12.2
2015	7	7	20	46	52	30	0	0	0	0	0	0	0	77.81	0	0	12.2
2015	7	7	20	56	52	30	0	0	0	0	0	0	0	77.63	0	0	12.2
2015	7	7	21	6	52	30	0	0	0	0	0	0	0	77.45	0	0	12.2
2015	7	7	21	16	52	29	0	0	0	0	0	0	0	77.25	0	0	12
2015	7	7	21	26	52	30	0	0	0	0	0	0	0	77.07	0	0	12
2015	7	7	21	36	52	30	0	0	0	0	0	0	0	76.86	0	0	12
2015	7	7	21	46	52	30	0	0	0	0	0	0	0	76.64	0	0	12
2015	7	7	21	56	52	30	0	0	0	0	0	0	0	76.42	0	0	12
2015	7	7	22	6	52	30	0	0	0	0	0	0	0	76.19	0	0	12
2015	7	7	22	16	52	31	0	0	0	0	0	0	0	75.94	0	0	12
2015	7	7	22	26	52	30	0	0	0	0	0	0	0	75.67	0	0	12
2015	7	7	22	36	52	30	0	0	0	0	0	0	0	75.42	0	0	12
2015	7	7	22	46	52	30	0	0	0	0	0	0	0	75.16	0	0	12
2015	7	7	22	56	52	30	0	0	0	0	0	0	0	74.93	0	0	12
2015	7	7	23	6	52	30	0	0	0	0	0	0	0	74.68	0	0	12
2015	7	7	23	16	52	32	0	0	0	0	0	0	0	74.44	0	0	12
2015	7	7	23	26	52	30	0	0	0	0	0	0	0	74.21	0	0	12
2015	7	7	23	36	52	30	0	0	0	0	0	0	0	74.01	0	0	12
2015	7	7	23	46	52	31	0	0	0	0	0	0	0	73.81	0	0	12
2015	7	7	23	56	52	30	0	0	0	0	0	0	0	73.6	0	0	12
2015	7	8	0	6	52	30	0	0	0	0	0	0	0	73.42	0	0	12
2015	7	8	0	16	52	30	0	0	0	0	0	0	0	73.26	0	0	12
2015	7	8	0	26	52	30	0	0	0	0	0	0	0	73.08	0	0	12
2015	7	8	0	36	52	31	0	0	0	0	0	0	0	72.93	0	0	12
2015	7	8	0	46	52	31	0	0	0	0	0	0	0	72.77	0	0	12
2015	7	8	0	56	52	31	0	0	0	0	0	0	0	72.64	0	0	12
2015	7	8	1	6	52	30	0	0	0	0	0	0	0	72.5	0	0	12
2015	7	8	1	16	52	30	0	0	0	0	0	0	0	72.39	0	0	12
2015	7	8	1	26	52	31	0	0	0	0	0	0	0	72.25	0	0	12
2015	7	8	1	36	52	30	0	0	0	0	0	0	0	72.12	0	0	12
2015	7	8	1	46	52	31	0	0	0	0	0	0	0	72	0	0	12
2015	7	8	1	56	52	31	0	0	0	0	0	0	0	71.89	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	8	2	6	52	31	0	0	0	0	0	0	0	71.76	0	0	12
2015	7	8	2	16	52	31	0	0	0	0	0	0	0	71.67	0	0	12
2015	7	8	2	26	52	30	0	0	0	0	0	0	0	71.56	0	0	12
2015	7	8	2	36	52	31	0	0	0	0	0	0	0	71.46	0	0	12
2015	7	8	2	46	52	31	0	0	0	0	0	0	0	71.37	0	0	12
2015	7	8	2	56	52	31	0	0	0	0	0	0	0	71.26	0	0	12
2015	7	8	3	6	52	31	0	0	0	0	0	0	0	71.15	0	0	12
2015	7	8	3	16	52	31	0	0	0	0	0	0	0	71.06	0	0	12
2015	7	8	3	26	52	31	0	0	0	0	0	0	0	70.97	0	0	12
2015	7	8	3	36	52	30	0	0	0	0	0	0	0	70.88	0	0	12
2015	7	8	3	46	52	31	0	0	0	0	0	0	0	70.79	0	0	12
2015	7	8	3	56	52	30	0	0	0	0	0	0	0	70.7	0	0	12
2015	7	8	4	6	52	31	0	0	0	0	0	0	0	70.59	0	0	12
2015	7	8	4	16	52	31	0	0	0	0	0	0	0	70.5	0	0	12
2015	7	8	4	26	52	31	0	0	0	0	0	0	0	70.43	0	0	12
2015	7	8	4	36	52	32	0	0	0	0	0	0	0	70.34	0	0	12
2015	7	8	4	46	52	31	0	0	0	0	0	0	0	70.25	0	0	12
2015	7	8	4	56	52	31	0	0	0	0	0	0	0	70.16	0	0	12
2015	7	8	5	6	52	31	0	0	0	0	0	0	0	70.05	0	0	12
2015	7	8	5	16	52	31	0	0	0	0	0	0	0	69.98	0	0	12
2015	7	8	5	26	52	31	0	0	0	0	0	0	0	69.89	0	0	12
2015	7	8	5	36	52	31	0	0	0	0	0	0	0	69.8	0	0	12
2015	7	8	5	46	52	31	0	0	0	0	0	0	0	69.71	0	0	12
2015	7	8	5	56	52	31	0	0	0	0	0	0	0	69.6	0	0	12
2015	7	8	6	6	52	31	0	0	0	0	0	0	0	69.51	0	0	12
2015	7	8	6	16	52	30	0	0	0	0	0	0	0	69.42	0	0	12
2015	7	8	6	26	52	31	0	0	0	0	0	0	0	69.35	0	0	12
2015	7	8	6	36	52	30	0	0	0	0	0	0	0	69.24	0	0	12
2015	7	8	6	46	52	31	0	0	0	0	0	0	0	69.19	0	0	12
2015	7	8	6	56	52	31	0	0	0	0	0	0	0	69.31	0	0	12.2
2015	7	8	7	6	52	30	0	0	0	0	0	0	0	69.33	0	0	12.4
2015	7	8	7	16	52	31	0	0	0	0	0	0	0	69.3	0	0	12.4
2015	7	8	7	26	52	31	0	0	0	0	0	0	0	69.3	0	0	12.6
2015	7	8	7	36	52	31	0	0	0	0	0	0	0	69.31	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	8	7	46	52	31	0	0	0	0	0	0	0	69.3	0	0	12.8
2015	7	8	7	56	52	32	0	0	0	0	0	0	0	69.33	0	0	13
2015	7	8	8	6	52	31	0	0	0	0	0	0	0	69.35	0	0	13
2015	7	8	8	16	52	31	0	0	0	0	0	0	0	69.35	0	0	13
2015	7	8	8	26	52	31	0	0	0	0	0	0	0	69.4	0	0	13.2
2015	7	8	8	36	52	31	0	0	0	0	0	0	0	69.51	0	0	13.2
2015	7	8	8	46	52	31	0	0	0	0	0	0	0	69.62	0	0	13.2
2015	7	8	8	56	52	31	0	0	0	0	0	0	0	69.69	0	0	13.2
2015	7	8	9	6	52	32	0	0	0	0	0	0	0	69.4	0	0	13
2015	7	8	9	16	52	31	0	0	0	0	0	0	0	69.4	0	0	13.2
2015	7	8	9	26	52	31	0	0	0	0	0	0	0	69.37	0	0	13
2015	7	8	9	36	52	30	0	0	0	0	0	0	0	69.19	0	0	12.6
2015	7	8	9	46	52	31	0	0	0	0	0	0	0	69.53	0	0	13.2
2015	7	8	9	56	52	31	0	0	0	0	0	0	0	70.11	0	0	13.4
2015	7	8	10	6	52	31	0	0	0	0	0	0	0	70.36	0	0	13.4
2015	7	8	10	16	52	31	0	0	0	0	0	0	0	70.43	0	0	13.2
2015	7	8	10	26	52	31	0	0	0	0	0	0	0	70.56	0	0	13.2
2015	7	8	10	36	52	31	0	0	0	0	0	0	0	70.65	0	0	13.2
2015	7	8	10	46	52	31	0	0	0	0	0	0	0	70.81	0	0	13.2
2015	7	8	10	56	52	31	0	0	0	0	0	0	0	71.01	0	0	13.2
2015	7	8	11	6	52	31	0	0	0	0	0	0	0	71.2	0	0	13.2
2015	7	8	11	16	52	31	0	0	0	0	0	0	0	71.44	0	0	13.4
2015	7	8	11	26	52	31	0	0	0	0	0	0	0	71.65	0	0	13.4
2015	7	8	11	36	52	31	0	0	0	0	0	0	0	71.85	0	0	13.4
2015	7	8	11	46	52	31	0	0	0	0	0	0	0	71.96	0	0	13.4
2015	7	8	11	56	52	32	0	0	0	0	0	0	0	71.22	0	0	13.4
2015	7	8	12	6	52	31	0	0	0	0	0	0	0	71.22	0	0	13.4
2015	7	8	12	16	52	31	0	0	0	0	0	0	0	71.42	0	0	13.4
2015	7	8	12	26	52	31	0	0	0	0	0	0	0	71.71	0	0	13.4
2015	7	8	12	36	52	31	0	0	0	0	0	0	0	71.96	0	0	13.4
2015	7	8	12	46	52	31	0	0	0	0	0	0	0	72.23	0	0	13.2
2015	7	8	12	56	52	30	0	0	0	0	0	0	0	72.52	0	0	13.2
2015	7	8	13	6	52	30	0	0	0	0	0	0	0	72.84	0	0	13.2
2015	7	8	13	16	52	31	0	0	0	0	0	0	0	73.42	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	8	13	26	52	31	0	0	0	0	0	0	0	74.43	0	0	13.2
2015	7	8	13	36	52	30	0	0	0	0	0	0	0	74.86	0	0	13.2
2015	7	8	13	46	52	31	0	0	0	0	0	0	0	75.2	0	0	13.2
2015	7	8	13	56	52	30	0	0	0	0	0	0	0	75.2	0	0	13.2
2015	7	8	14	6	52	30	0	0	0	0	0	0	0	74.82	0	0	12.8
2015	7	8	14	16	52	31	0	0	0	0	0	0	0	74.84	0	0	12.6
2015	7	8	14	26	52	31	0	0	0	0	0	0	0	74.91	0	0	12.8
2015	7	8	14	36	52	30	0	0	0	0	0	0	0	74.93	0	0	12.8
2015	7	8	14	46	52	30	0	0	0	0	0	0	0	75	0	0	12.8
2015	7	8	14	56	52	30	0	0	0	0	0	0	0	75.15	0	0	13
2015	7	8	15	6	52	31	0	0	0	0	0	0	0	74.88	0	0	12.6
2015	7	8	15	16	52	30	0	0	0	0	0	0	0	74.82	0	0	12.6
2015	7	8	15	26	52	30	0	0	0	0	0	0	0	74.75	0	0	12.4
2015	7	8	15	36	52	31	0	0	0	0	0	0	0	74.77	0	0	12.6
2015	7	8	15	46	52	31	0	0	0	0	0	0	0	74.82	0	0	12.6
2015	7	8	15	56	52	31	0	0	0	0	0	0	0	75.02	0	0	12.8
2015	7	8	16	6	52	30	0	0	0	0	0	0	0	74.88	0	0	12.6
2015	7	8	16	16	52	30	0	0	0	0	0	0	0	74.88	0	0	12.6
2015	7	8	16	26	52	31	0	0	0	0	0	0	0	74.89	0	0	12.4
2015	7	8	16	36	52	30	0	0	0	0	0	0	0	74.84	0	0	12.4
2015	7	8	16	46	52	31	0	0	0	0	0	0	0	74.77	0	0	12.2
2015	7	8	16	56	52	30	0	0	0	0	0	0	0	74.82	0	0	12.4
2015	7	8	17	6	52	30	0	0	0	0	0	0	0	74.8	0	0	12.4
2015	7	8	17	16	52	31	0	0	0	0	0	0	0	74.79	0	0	12.2
2015	7	8	17	26	52	31	0	0	0	0	0	0	0	74.75	0	0	12.2
2015	7	8	17	36	52	31	0	0	0	0	0	0	0	74.71	0	0	12.2
2015	7	8	17	46	52	30	0	0	0	0	0	0	0	74.68	0	0	12.2
2015	7	8	17	56	52	30	0	0	0	0	0	0	0	74.64	0	0	12.2
2015	7	8	18	6	52	31	0	0	0	0	0	0	0	74.61	0	0	12.2
2015	7	8	18	16	52	31	0	0	0	0	0	0	0	74.55	0	0	12.2
2015	7	8	18	26	52	30	0	0	0	0	0	0	0	74.48	0	0	12.2
2015	7	8	18	36	52	31	0	0	0	0	0	0	0	74.35	0	0	12.2
2015	7	8	18	46	52	30	0	0	0	0	0	0	0	74.3	0	0	12.2
2015	7	8	18	56	52	31	0	0	0	0	0	0	0	74.19	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	8	19	6	52	31	0	0	0	0	0	0	0	74.03	0	0	12.2
2015	7	8	19	16	52	31	0	0	0	0	0	0	0	73.85	0	0	12.2
2015	7	8	19	26	52	30	0	0	0	0	0	0	0	73.65	0	0	12.2
2015	7	8	19	36	52	31	0	0	0	0	0	0	0	73.47	0	0	12.2
2015	7	8	19	46	52	31	0	0	0	0	0	0	0	73.29	0	0	12.2
2015	7	8	19	56	52	30	0	0	0	0	0	0	0	73.11	0	0	12.2
2015	7	8	20	6	52	31	0	0	0	0	0	0	0	72.93	0	0	12
2015	7	8	20	16	52	30	0	0	0	0	0	0	0	72.77	0	0	12
2015	7	8	20	26	52	31	0	0	0	0	0	0	0	72.61	0	0	12
2015	7	8	20	36	52	31	0	0	0	0	0	0	0	72.45	0	0	12
2015	7	8	20	46	52	31	0	0	0	0	0	0	0	72.27	0	0	12
2015	7	8	20	56	52	31	0	0	0	0	0	0	0	72.09	0	0	12
2015	7	8	21	6	52	31	0	0	0	0	0	0	0	71.91	0	0	12
2015	7	8	21	16	52	31	0	0	0	0	0	0	0	71.73	0	0	12
2015	7	8	21	26	52	30	0	0	0	0	0	0	0	71.56	0	0	12
2015	7	8	21	36	52	31	0	0	0	0	0	0	0	71.37	0	0	12
2015	7	8	21	46	52	30	0	0	0	0	0	0	0	71.19	0	0	12
2015	7	8	21	56	52	30	0	0	0	0	0	0	0	70.99	0	0	12
2015	7	8	22	6	52	30	0	0	0	0	0	0	0	70.79	0	0	12
2015	7	8	22	16	52	31	0	0	0	0	0	0	0	70.59	0	0	12
2015	7	8	22	26	52	32	0	0	0	0	0	0	0	70.39	0	0	12
2015	7	8	22	36	52	30	0	0	0	0	0	0	0	70.21	0	0	12
2015	7	8	22	46	52	31	0	0	0	0	0	0	0	70.02	0	0	12
2015	7	8	22	56	52	32	0	0	0	0	0	0	0	69.84	0	0	12
2015	7	8	23	6	52	31	0	0	0	0	0	0	0	69.66	0	0	12
2015	7	8	23	16	52	31	0	0	0	0	0	0	0	69.48	0	0	12
2015	7	8	23	26	52	31	0	0	0	0	0	0	0	69.31	0	0	12
2015	7	8	23	36	52	31	0	0	0	0	0	0	0	69.17	0	0	12
2015	7	8	23	46	52	32	0	0	0	0	0	0	0	69.03	0	0	12
2015	7	8	23	56	52	31	0	0	0	0	0	0	0	68.88	0	0	12
2015	7	9	0	6	52	31	0	0	0	0	0	0	0	68.74	0	0	12
2015	7	9	0	16	52	31	0	0	0	0	0	0	0	68.61	0	0	12
2015	7	9	0	26	52	31	0	0	0	0	0	0	0	68.49	0	0	12
2015	7	9	0	36	52	32	0	0	0	0	0	0	0	68.36	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	9	0	46	52	31	0	0	0	0	0	0	0	68.25	0	0	12
2015	7	9	0	56	52	32	0	0	0	0	0	0	0	68.13	0	0	12
2015	7	9	1	6	52	31	0	0	0	0	0	0	0	68	0	0	12
2015	7	9	1	16	52	31	0	0	0	0	0	0	0	67.86	0	0	12
2015	7	9	1	26	52	32	0	0	0	0	0	0	0	67.75	0	0	12
2015	7	9	1	36	52	31	0	0	0	0	0	0	0	67.62	0	0	12
2015	7	9	1	46	52	31	0	0	0	0	0	0	0	67.5	0	0	12
2015	7	9	1	56	52	31	0	0	0	0	0	0	0	67.39	0	0	12
2015	7	9	2	6	52	31	0	0	0	0	0	0	0	67.28	0	0	12
2015	7	9	2	16	52	31	0	0	0	0	0	0	0	67.17	0	0	12
2015	7	9	2	26	52	32	0	0	0	0	0	0	0	67.06	0	0	12
2015	7	9	2	36	52	31	0	0	0	0	0	0	0	66.96	0	0	12
2015	7	9	2	46	52	33	0	0	0	0	0	0	0	66.85	0	0	12
2015	7	9	2	56	52	32	0	0	0	0	0	0	0	66.74	0	0	12
2015	7	9	3	6	52	31	0	0	0	0	0	0	0	66.63	0	0	12
2015	7	9	3	16	52	32	0	0	0	0	0	0	0	66.51	0	0	12
2015	7	9	3	26	52	31	0	0	0	0	0	0	0	66.4	0	0	12
2015	7	9	3	36	52	31	0	0	0	0	0	0	0	66.29	0	0	12
2015	7	9	3	46	52	31	0	0	0	0	0	0	0	66.2	0	0	12
2015	7	9	3	56	52	31	0	0	0	0	0	0	0	66.09	0	0	12
2015	7	9	4	6	52	32	0	0	0	0	0	0	0	66	0	0	12
2015	7	9	4	16	52	31	0	0	0	0	0	0	0	65.91	0	0	12
2015	7	9	4	26	52	31	0	0	0	0	0	0	0	65.82	0	0	12
2015	7	9	4	36	52	31	0	0	0	0	0	0	0	65.73	0	0	11.8
2015	7	9	4	46	52	31	0	0	0	0	0	0	0	65.64	0	0	11.8
2015	7	9	4	56	52	31	0	0	0	0	0	0	0	65.55	0	0	11.8
2015	7	9	5	6	52	32	0	0	0	0	0	0	0	65.46	0	0	11.8
2015	7	9	5	16	52	32	0	0	0	0	0	0	0	65.37	0	0	11.8
2015	7	9	5	26	52	31	0	0	0	0	0	0	0	65.28	0	0	11.8
2015	7	9	5	36	52	32	0	0	0	0	0	0	0	65.19	0	0	11.8
2015	7	9	5	46	52	31	0	0	0	0	0	0	0	65.12	0	0	11.8
2015	7	9	5	56	52	32	0	0	0	0	0	0	0	65.05	0	0	12
2015	7	9	6	6	52	31	0	0	0	0	0	0	0	64.99	0	0	12
2015	7	9	6	16	52	32	0	0	0	0	0	0	0	64.94	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	9	6	26	52	31	0	0	0	0	0	0	0	64.87	0	0	12
2015	7	9	6	36	52	31	0	0	0	0	0	0	0	64.8	0	0	12
2015	7	9	6	46	52	32	0	0	0	0	0	0	0	64.74	0	0	12
2015	7	9	6	56	52	32	0	0	0	0	0	0	0	64.81	0	0	12.2
2015	7	9	7	6	52	31	0	0	0	0	0	0	0	64.85	0	0	12.2
2015	7	9	7	16	52	31	0	0	0	0	0	0	0	64.92	0	0	12.4
2015	7	9	7	26	52	32	0	0	0	0	0	0	0	64.94	0	0	12.4
2015	7	9	7	36	52	32	0	0	0	0	0	0	0	64.87	0	0	12.4
2015	7	9	7	46	52	32	0	0	0	0	0	0	0	65.05	0	0	12.8
2015	7	9	7	56	52	31	0	0	0	0	0	0	0	65.12	0	0	12.8
2015	7	9	8	6	52	31	0	0	0	0	0	0	0	65.21	0	0	13
2015	7	9	8	16	52	32	0	0	0	0	0	0	0	65.28	0	0	13
2015	7	9	8	26	52	32	0	0	0	0	0	0	0	65.37	0	0	13.2
2015	7	9	8	36	52	32	0	0	0	0	0	0	0	65.43	0	0	13.2
2015	7	9	8	46	52	33	0	0	0	0	0	0	0	65.53	0	0	13.2
2015	7	9	8	56	52	32	0	0	0	0	0	0	0	65.64	0	0	13.2
2015	7	9	9	6	52	32	0	0	0	0	0	0	0	65.77	0	0	13.2
2015	7	9	9	16	52	31	0	0	0	0	0	0	0	65.91	0	0	13.4
2015	7	9	9	26	52	32	0	0	0	0	0	0	0	66.06	0	0	13.4
2015	7	9	9	36	52	32	0	0	0	0	0	0	0	66.38	0	0	13.4
2015	7	9	9	46	52	32	0	0	0	0	0	0	0	65.88	0	0	13.2
2015	7	9	9	56	52	31	0	0	0	0	0	0	0	65.61	0	0	13
2015	7	9	10	6	52	32	0	0	0	0	0	0	0	65.62	0	0	13
2015	7	9	10	16	52	32	0	0	0	0	0	0	0	65.66	0	0	13
2015	7	9	10	26	52	31	0	0	0	0	0	0	0	65.82	0	0	13
2015	7	9	10	36	52	31	0	0	0	0	0	0	0	65.95	0	0	13
2015	7	9	10	46	52	31	0	0	0	0	0	0	0	66.27	0	0	13.2
2015	7	9	10	56	52	31	0	0	0	0	0	0	0	66.11	0	0	13
2015	7	9	11	6	52	32	0	0	0	0	0	0	0	66.63	0	0	13.2
2015	7	9	11	16	52	32	0	0	0	0	0	0	0	66.18	0	0	12.8
2015	7	9	11	26	52	31	0	0	0	0	0	0	0	66.11	0	0	12.6
2015	7	9	11	36	52	32	0	0	0	0	0	0	0	65.8	0	0	12.4
2015	7	9	11	46	52	32	0	0	0	0	0	0	0	65.61	0	0	12.2
2015	7	9	11	56	52	32	0	0	0	0	0	0	0	65.55	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	9	12	6	52	32	0	0	0	0	0	0	0	65.55	0	0	12.2
2015	7	9	12	16	52	32	0	0	0	0	0	0	0	65.52	0	0	12.2
2015	7	9	12	26	52	31	0	0	0	0	0	0	0	65.44	0	0	12.2
2015	7	9	12	36	52	31	0	0	0	0	0	0	0	65.43	0	0	12.2
2015	7	9	12	46	52	31	0	0	0	0	0	0	0	65.39	0	0	12.2
2015	7	9	12	56	52	32	0	0	0	0	0	0	0	65.39	0	0	12.2
2015	7	9	13	6	52	32	0	0	0	0	0	0	0	65.43	0	0	12.2
2015	7	9	13	16	52	30	0	0	0	0	0	0	0	65.48	0	0	12.2
2015	7	9	13	26	52	32	0	0	0	0	0	0	0	65.57	0	0	12.4
2015	7	9	13	36	52	32	0	0	0	0	0	0	0	65.77	0	0	12.6
2015	7	9	13	46	52	31	0	0	0	0	0	0	0	65.95	0	0	12.8
2015	7	9	13	56	52	31	0	0	0	0	0	0	0	66.09	0	0	12.8
2015	7	9	14	6	52	31	0	0	0	0	0	0	0	66.27	0	0	13
2015	7	9	14	16	52	31	0	0	0	0	0	0	0	66.38	0	0	13
2015	7	9	14	26	52	32	0	0	0	0	0	0	0	66.47	0	0	13
2015	7	9	14	36	52	32	0	0	0	0	0	0	0	66.65	0	0	13
2015	7	9	14	46	52	31	0	0	0	0	0	0	0	66.81	0	0	13.2
2015	7	9	14	56	52	31	0	0	0	0	0	0	0	67.06	0	0	13.4
2015	7	9	15	6	52	32	0	0	0	0	0	0	0	67.12	0	0	13.4
2015	7	9	15	16	52	31	0	0	0	0	0	0	0	66.99	0	0	12.8
2015	7	9	15	26	52	32	0	0	0	0	0	0	0	67.05	0	0	12.8
2015	7	9	15	36	52	31	0	0	0	0	0	0	0	66.99	0	0	12.6
2015	7	9	15	46	52	32	0	0	0	0	0	0	0	66.99	0	0	12.6
2015	7	9	15	56	52	31	0	0	0	0	0	0	0	67.15	0	0	12.8
2015	7	9	16	6	52	30	0	0	0	0	0	0	0	67.28	0	0	12.8
2015	7	9	16	16	52	31	0	0	0	0	0	0	0	67.23	0	0	12.6
2015	7	9	16	26	52	31	0	0	0	0	0	0	0	67.01	0	0	12.4
2015	7	9	16	36	52	31	0	0	0	0	0	0	0	66.94	0	0	12.4
2015	7	9	16	46	52	32	0	0	0	0	0	0	0	66.97	0	0	12.4
2015	7	9	16	56	52	32	0	0	0	0	0	0	0	67.55	0	0	12.6
2015	7	9	17	6	52	31	0	0	0	0	0	0	0	67.64	0	0	12.4
2015	7	9	17	16	52	32	0	0	0	0	0	0	0	67.69	0	0	12.4
2015	7	9	17	26	52	31	0	0	0	0	0	0	0	67.71	0	0	12.4
2015	7	9	17	36	52	31	0	0	0	0	0	0	0	67.59	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	9	17	46	52	31	0	0	0	0	0	0	0	67.37	0	0	12.2
2015	7	9	17	56	52	32	0	0	0	0	0	0	0	67.35	0	0	12.2
2015	7	9	18	6	52	31	0	0	0	0	0	0	0	67.37	0	0	12.2
2015	7	9	18	16	52	32	0	0	0	0	0	0	0	67.41	0	0	12.2
2015	7	9	18	26	52	31	0	0	0	0	0	0	0	67.42	0	0	12.2
2015	7	9	18	36	52	31	0	0	0	0	0	0	0	67.42	0	0	12.2
2015	7	9	18	46	52	32	0	0	0	0	0	0	0	67.41	0	0	12.2
2015	7	9	18	56	52	31	0	0	0	0	0	0	0	67.39	0	0	12.2
2015	7	9	19	6	52	32	0	0	0	0	0	0	0	67.35	0	0	12.2
2015	7	9	19	16	52	32	0	0	0	0	0	0	0	67.3	0	0	12.2
2015	7	9	19	26	52	31	0	0	0	0	0	0	0	67.24	0	0	12
2015	7	9	19	36	52	32	0	0	0	0	0	0	0	67.17	0	0	12
2015	7	9	19	46	52	31	0	0	0	0	0	0	0	67.12	0	0	12
2015	7	9	19	56	52	31	0	0	0	0	0	0	0	67.03	0	0	12
2015	7	9	20	6	52	31	0	0	0	0	0	0	0	66.96	0	0	12
2015	7	9	20	16	52	32	0	0	0	0	0	0	0	66.87	0	0	12
2015	7	9	20	26	52	31	0	0	0	0	0	0	0	66.81	0	0	12
2015	7	9	20	36	52	31	0	0	0	0	0	0	0	66.76	0	0	12
2015	7	9	20	46	52	32	0	0	0	0	0	0	0	66.7	0	0	12
2015	7	9	20	56	52	32	0	0	0	0	0	0	0	66.65	0	0	12
2015	7	9	21	6	52	32	0	0	0	0	0	0	0	66.61	0	0	12
2015	7	9	21	16	52	32	0	0	0	0	0	0	0	66.56	0	0	12
2015	7	9	21	26	52	30	0	0	0	0	0	0	0	66.51	0	0	12
2015	7	9	21	36	52	32	0	0	0	0	0	0	0	66.45	0	0	12
2015	7	9	21	46	52	32	0	0	0	0	0	0	0	66.4	0	0	12
2015	7	9	21	56	52	31	0	0	0	0	0	0	0	66.34	0	0	12
2015	7	9	22	6	52	32	0	0	0	0	0	0	0	66.29	0	0	12
2015	7	9	22	16	52	31	0	0	0	0	0	0	0	66.24	0	0	12
2015	7	9	22	26	52	32	0	0	0	0	0	0	0	66.18	0	0	12
2015	7	9	22	36	52	31	0	0	0	0	0	0	0	66.13	0	0	12
2015	7	9	22	46	52	31	0	0	0	0	0	0	0	66.07	0	0	12
2015	7	9	22	56	52	30	0	0	0	0	0	0	0	66	0	0	12
2015	7	9	23	6	52	31	0	0	0	0	0	0	0	65.95	0	0	12
2015	7	9	23	16	52	32	0	0	0	0	0	0	0	65.86	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	9	23	26	52	32	0	0	0	0	0	0	0	65.79	0	0	12
2015	7	9	23	36	52	31	0	0	0	0	0	0	0	65.71	0	0	12
2015	7	9	23	46	52	32	0	0	0	0	0	0	0	65.62	0	0	12
2015	7	9	23	56	52	32	0	0	0	0	0	0	0	65.53	0	0	12
2015	7	10	0	6	52	32	0	0	0	0	0	0	0	65.48	0	0	12
2015	7	10	0	16	52	31	0	0	0	0	0	0	0	65.39	0	0	11.8
2015	7	10	0	26	52	31	0	0	0	0	0	0	0	65.3	0	0	11.8
2015	7	10	0	36	52	32	0	0	0	0	0	0	0	65.23	0	0	11.8
2015	7	10	0	46	52	32	0	0	0	0	0	0	0	65.16	0	0	11.8
2015	7	10	0	56	52	32	0	0	0	0	0	0	0	65.08	0	0	11.8
2015	7	10	1	6	52	32	0	0	0	0	0	0	0	65.03	0	0	11.8
2015	7	10	1	16	52	32	0	0	0	0	0	0	0	64.96	0	0	11.8
2015	7	10	1	26	52	31	0	0	0	0	0	0	0	64.9	0	0	11.8
2015	7	10	1	36	52	31	0	0	0	0	0	0	0	64.83	0	0	11.8
2015	7	10	1	46	52	32	0	0	0	0	0	0	0	64.8	0	0	11.8
2015	7	10	1	56	52	31	0	0	0	0	0	0	0	64.74	0	0	11.8
2015	7	10	2	6	52	32	0	0	0	0	0	0	0	64.67	0	0	11.8
2015	7	10	2	16	52	32	0	0	0	0	0	0	0	64.6	0	0	11.8
2015	7	10	2	26	52	32	0	0	0	0	0	0	0	64.53	0	0	11.8
2015	7	10	2	36	52	32	0	0	0	0	0	0	0	64.45	0	0	11.8
2015	7	10	2	46	52	32	0	0	0	0	0	0	0	64.38	0	0	11.8
2015	7	10	2	56	52	32	0	0	0	0	0	0	0	64.31	0	0	11.8
2015	7	10	3	6	52	32	0	0	0	0	0	0	0	64.24	0	0	11.8
2015	7	10	3	16	52	31	0	0	0	0	0	0	0	64.17	0	0	11.8
2015	7	10	3	26	52	32	0	0	0	0	0	0	0	64.11	0	0	11.8
2015	7	10	3	36	52	31	0	0	0	0	0	0	0	64.06	0	0	11.8
2015	7	10	3	46	52	31	0	0	0	0	0	0	0	64	0	0	11.8
2015	7	10	3	56	52	32	0	0	0	0	0	0	0	63.93	0	0	11.8
2015	7	10	4	6	52	31	0	0	0	0	0	0	0	63.88	0	0	11.8
2015	7	10	4	16	52	32	0	0	0	0	0	0	0	63.82	0	0	11.8
2015	7	10	4	26	52	31	0	0	0	0	0	0	0	63.79	0	0	11.8
2015	7	10	4	36	52	32	0	0	0	0	0	0	0	63.73	0	0	11.8
2015	7	10	4	46	52	32	0	0	0	0	0	0	0	63.68	0	0	11.8
2015	7	10	4	56	52	32	0	0	0	0	0	0	0	63.63	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	10	5	6	52	32	0	0	0	0	0	0	0	63.59	0	0	11.8
2015	7	10	5	16	52	31	0	0	0	0	0	0	0	63.54	0	0	11.8
2015	7	10	5	26	52	32	0	0	0	0	0	0	0	63.48	0	0	11.8
2015	7	10	5	36	52	31	0	0	0	0	0	0	0	63.43	0	0	11.8
2015	7	10	5	46	52	33	0	0	0	0	0	0	0	63.39	0	0	11.8
2015	7	10	5	56	52	32	0	0	0	0	0	0	0	63.32	0	0	11.8
2015	7	10	6	6	52	31	0	0	0	0	0	0	0	63.28	0	0	11.8
2015	7	10	6	16	52	31	0	0	0	0	0	0	0	63.21	0	0	11.8
2015	7	10	6	26	52	32	0	0	0	0	0	0	0	63.16	0	0	11.8
2015	7	10	6	36	52	31	0	0	0	0	0	0	0	63.1	0	0	11.8
2015	7	10	6	46	52	32	0	0	0	0	0	0	0	63.05	0	0	11.8
2015	7	10	6	56	52	32	0	0	0	0	0	0	0	63.25	0	0	12
2015	7	10	7	6	52	32	0	0	0	0	0	0	0	63.34	0	0	12.2
2015	7	10	7	16	52	31	0	0	0	0	0	0	0	63.43	0	0	12.4
2015	7	10	7	26	52	32	0	0	0	0	0	0	0	63.5	0	0	12.6
2015	7	10	7	36	52	32	0	0	0	0	0	0	0	63.59	0	0	12.6
2015	7	10	7	46	52	31	0	0	0	0	0	0	0	63.72	0	0	12.8
2015	7	10	7	56	52	32	0	0	0	0	0	0	0	63.73	0	0	12.8
2015	7	10	8	6	52	32	0	0	0	0	0	0	0	64.13	0	0	13
2015	7	10	8	16	52	32	0	0	0	0	0	0	0	64.15	0	0	13
2015	7	10	8	26	52	32	0	0	0	0	0	0	0	63.9	0	0	12.8
2015	7	10	8	36	52	31	0	0	0	0	0	0	0	63.75	0	0	12.8
2015	7	10	8	46	52	32	0	0	0	0	0	0	0	63.97	0	0	12.8
2015	7	10	8	56	52	32	0	0	0	0	0	0	0	64.2	0	0	13
2015	7	10	9	6	52	32	0	0	0	0	0	0	0	64.49	0	0	13.2
2015	7	10	9	16	52	32	0	0	0	0	0	0	0	64.9	0	0	13.2
2015	7	10	9	26	52	32	0	0	0	0	0	0	0	65.14	0	0	13.2
2015	7	10	9	36	52	32	0	0	0	0	0	0	0	65.5	0	0	13.4
2015	7	10	9	46	52	32	0	0	0	0	0	0	0	65.82	0	0	13.4
2015	7	10	9	56	52	31	0	0	0	0	0	0	0	65.12	0	0	13.4
2015	7	10	10	6	52	32	0	0	0	0	0	0	0	65.32	0	0	13.2
2015	7	10	10	16	52	32	0	0	0	0	0	0	0	65.39	0	0	13.2
2015	7	10	10	26	52	32	0	0	0	0	0	0	0	65.26	0	0	13
2015	7	10	10	36	52	32	0	0	0	0	0	0	0	65.89	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	10	10	46	52	32	0	0	0	0	0	0	0	65.75	0	0	13.2
2015	7	10	10	56	52	32	0	0	0	0	0	0	0	66	0	0	13.2
2015	7	10	11	6	52	30	0	0	0	0	0	0	0	66.7	0	0	13.4
2015	7	10	11	16	52	31	0	0	0	0	0	0	0	66.97	0	0	13.2
2015	7	10	11	26	52	32	0	0	0	0	0	0	0	67.12	0	0	13.2
2015	7	10	11	36	52	31	0	0	0	0	0	0	0	67.28	0	0	13.2
2015	7	10	11	46	52	31	0	0	0	0	0	0	0	67.51	0	0	13.2
2015	7	10	11	56	52	32	0	0	0	0	0	0	0	66.76	0	0	13.2
2015	7	10	12	6	52	31	0	0	0	0	0	0	0	66.85	0	0	13.2
2015	7	10	12	16	52	31	0	0	0	0	0	0	0	67.12	0	0	13.2
2015	7	10	12	26	52	31	0	0	0	0	0	0	0	67.48	0	0	13.2
2015	7	10	12	36	52	31	0	0	0	0	0	0	0	67.82	0	0	12.6
2015	7	10	12	46	52	31	0	0	0	0	0	0	0	68.22	0	0	13.4
2015	7	10	12	56	52	31	0	0	0	0	0	0	0	68.5	0	0	13.4
2015	7	10	13	6	52	31	0	0	0	0	0	0	0	68.85	0	0	13.4
2015	7	10	13	16	52	31	0	0	0	0	0	0	0	69.75	0	0	13.4
2015	7	10	13	26	52	31	0	0	0	0	0	0	0	70.48	0	0	13.4
2015	7	10	13	36	52	31	0	0	0	0	0	0	0	70.83	0	0	13.4
2015	7	10	13	46	52	32	0	0	0	0	0	0	0	70.52	0	0	13
2015	7	10	13	56	52	31	0	0	0	0	0	0	0	70.72	0	0	12.8
2015	7	10	14	6	52	31	0	0	0	0	0	0	0	70.92	0	0	12.8
2015	7	10	14	16	52	32	0	0	0	0	0	0	0	71.08	0	0	12.8
2015	7	10	14	26	52	31	0	0	0	0	0	0	0	71.17	0	0	12.6
2015	7	10	14	36	52	31	0	0	0	0	0	0	0	71.26	0	0	12.6
2015	7	10	14	46	52	30	0	0	0	0	0	0	0	71.28	0	0	12.6
2015	7	10	14	56	52	31	0	0	0	0	0	0	0	71.31	0	0	12.6
2015	7	10	15	6	52	31	0	0	0	0	0	0	0	71.4	0	0	12.6
2015	7	10	15	16	52	30	0	0	0	0	0	0	0	71.44	0	0	12.6
2015	7	10	15	26	52	31	0	0	0	0	0	0	0	71.4	0	0	12.6
2015	7	10	15	36	52	31	0	0	0	0	0	0	0	71.38	0	0	12.4
2015	7	10	15	46	52	31	0	0	0	0	0	0	0	71.29	0	0	12.4
2015	7	10	15	56	52	30	0	0	0	0	0	0	0	71.29	0	0	12.2
2015	7	10	16	6	52	30	0	0	0	0	0	0	0	71.31	0	0	12.2
2015	7	10	16	16	52	31	0	0	0	0	0	0	0	71.33	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	10	16	26	52	31	0	0	0	0	0	0	0	71.35	0	0	12.2
2015	7	10	16	36	52	30	0	0	0	0	0	0	0	71.35	0	0	12.2
2015	7	10	16	46	52	32	0	0	0	0	0	0	0	71.33	0	0	12.2
2015	7	10	16	56	52	31	0	0	0	0	0	0	0	71.33	0	0	12.2
2015	7	10	17	6	52	31	0	0	0	0	0	0	0	71.33	0	0	12.2
2015	7	10	17	16	52	30	0	0	0	0	0	0	0	71.31	0	0	12.2
2015	7	10	17	26	52	31	0	0	0	0	0	0	0	71.29	0	0	12.2
2015	7	10	17	36	52	31	0	0	0	0	0	0	0	71.31	0	0	12.2
2015	7	10	17	46	52	31	0	0	0	0	0	0	0	71.31	0	0	12.2
2015	7	10	17	56	52	31	0	0	0	0	0	0	0	71.35	0	0	12.2
2015	7	10	18	6	52	31	0	0	0	0	0	0	0	71.4	0	0	12.2
2015	7	10	18	16	52	31	0	0	0	0	0	0	0	71.42	0	0	12.2
2015	7	10	18	26	52	31	0	0	0	0	0	0	0	71.44	0	0	12.2
2015	7	10	18	36	52	31	0	0	0	0	0	0	0	71.46	0	0	12.2
2015	7	10	18	46	52	31	0	0	0	0	0	0	0	71.47	0	0	12.2
2015	7	10	18	56	52	31	0	0	0	0	0	0	0	71.47	0	0	12.2
2015	7	10	19	6	52	30	0	0	0	0	0	0	0	71.44	0	0	12.2
2015	7	10	19	16	52	31	0	0	0	0	0	0	0	71.42	0	0	12.2
2015	7	10	19	26	52	31	0	0	0	0	0	0	0	71.38	0	0	12
2015	7	10	19	36	52	31	0	0	0	0	0	0	0	71.35	0	0	12
2015	7	10	19	46	52	31	0	0	0	0	0	0	0	71.29	0	0	12
2015	7	10	19	56	52	31	0	0	0	0	0	0	0	71.24	0	0	12
2015	7	10	20	6	52	31	0	0	0	0	0	0	0	71.17	0	0	12
2015	7	10	20	16	52	32	0	0	0	0	0	0	0	71.08	0	0	12
2015	7	10	20	26	52	32	0	0	0	0	0	0	0	70.97	0	0	12
2015	7	10	20	36	52	30	0	0	0	0	0	0	0	70.86	0	0	12
2015	7	10	20	46	52	31	0	0	0	0	0	0	0	70.77	0	0	12
2015	7	10	20	56	52	31	0	0	0	0	0	0	0	70.66	0	0	12
2015	7	10	21	6	52	31	0	0	0	0	0	0	0	70.56	0	0	12
2015	7	10	21	16	52	31	0	0	0	0	0	0	0	70.45	0	0	12
2015	7	10	21	26	52	31	0	0	0	0	0	0	0	70.34	0	0	12
2015	7	10	21	36	52	31	0	0	0	0	0	0	0	70.23	0	0	12
2015	7	10	21	46	52	31	0	0	0	0	0	0	0	70.14	0	0	12
2015	7	10	21	56	52	32	0	0	0	0	0	0	0	70.03	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	10	22	6	52	31	0	0	0	0	0	0	0	69.91	0	0	12
2015	7	10	22	16	52	31	0	0	0	0	0	0	0	69.82	0	0	12
2015	7	10	22	26	52	31	0	0	0	0	0	0	0	69.69	0	0	12
2015	7	10	22	36	52	32	0	0	0	0	0	0	0	69.57	0	0	12
2015	7	10	22	46	52	31	0	0	0	0	0	0	0	69.42	0	0	12
2015	7	10	22	56	52	31	0	0	0	0	0	0	0	69.3	0	0	12
2015	7	10	23	6	52	30	0	0	0	0	0	0	0	69.15	0	0	12
2015	7	10	23	16	52	32	0	0	0	0	0	0	0	69.03	0	0	12
2015	7	10	23	26	52	31	0	0	0	0	0	0	0	68.9	0	0	12
2015	7	10	23	36	52	31	0	0	0	0	0	0	0	68.77	0	0	12
2015	7	10	23	46	52	32	0	0	0	0	0	0	0	68.67	0	0	12
2015	7	10	23	56	52	31	0	0	0	0	0	0	0	68.52	0	0	12
2015	7	11	0	6	52	32	0	0	0	0	0	0	0	68.41	0	0	12
2015	7	11	0	16	52	31	0	0	0	0	0	0	0	68.29	0	0	12
2015	7	11	0	26	52	31	0	0	0	0	0	0	0	68.18	0	0	12
2015	7	11	0	36	52	31	0	0	0	0	0	0	0	68.07	0	0	12
2015	7	11	0	46	52	31	0	0	0	0	0	0	0	67.95	0	0	12
2015	7	11	0	56	52	31	0	0	0	0	0	0	0	67.84	0	0	12
2015	7	11	1	6	52	31	0	0	0	0	0	0	0	67.71	0	0	12
2015	7	11	1	16	52	32	0	0	0	0	0	0	0	67.59	0	0	12
2015	7	11	1	26	52	31	0	0	0	0	0	0	0	67.48	0	0	12
2015	7	11	1	36	52	31	0	0	0	0	0	0	0	67.37	0	0	12
2015	7	11	1	46	52	32	0	0	0	0	0	0	0	67.26	0	0	12
2015	7	11	1	56	52	32	0	0	0	0	0	0	0	67.15	0	0	12
2015	7	11	2	6	52	31	0	0	0	0	0	0	0	67.05	0	0	12
2015	7	11	2	16	52	31	0	0	0	0	0	0	0	66.97	0	0	11.8
2015	7	11	2	26	52	31	0	0	0	0	0	0	0	66.87	0	0	11.8
2015	7	11	2	36	52	32	0	0	0	0	0	0	0	66.78	0	0	11.8
2015	7	11	2	46	52	31	0	0	0	0	0	0	0	66.69	0	0	11.8
2015	7	11	2	56	52	32	0	0	0	0	0	0	0	66.61	0	0	11.8
2015	7	11	3	6	52	32	0	0	0	0	0	0	0	66.54	0	0	11.8
2015	7	11	3	16	52	31	0	0	0	0	0	0	0	66.47	0	0	11.8
2015	7	11	3	26	52	32	0	0	0	0	0	0	0	66.38	0	0	11.8
2015	7	11	3	36	52	32	0	0	0	0	0	0	0	66.31	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	11	3	46	52	31	0	0	0	0	0	0	0	66.24	0	0	11.8
2015	7	11	3	56	52	31	0	0	0	0	0	0	0	66.16	0	0	11.8
2015	7	11	4	6	52	32	0	0	0	0	0	0	0	66.09	0	0	11.8
2015	7	11	4	16	52	32	0	0	0	0	0	0	0	66.02	0	0	11.8
2015	7	11	4	26	52	32	0	0	0	0	0	0	0	65.97	0	0	11.8
2015	7	11	4	36	52	31	0	0	0	0	0	0	0	65.91	0	0	11.8
2015	7	11	4	46	52	32	0	0	0	0	0	0	0	65.84	0	0	11.8
2015	7	11	4	56	52	32	0	0	0	0	0	0	0	65.77	0	0	11.8
2015	7	11	5	6	52	32	0	0	0	0	0	0	0	65.7	0	0	11.8
2015	7	11	5	16	52	32	0	0	0	0	0	0	0	65.64	0	0	11.8
2015	7	11	5	26	52	32	0	0	0	0	0	0	0	65.55	0	0	11.8
2015	7	11	5	36	52	32	0	0	0	0	0	0	0	65.48	0	0	11.8
2015	7	11	5	46	52	32	0	0	0	0	0	0	0	65.43	0	0	11.8
2015	7	11	5	56	52	31	0	0	0	0	0	0	0	65.37	0	0	11.8
2015	7	11	6	6	52	32	0	0	0	0	0	0	0	65.32	0	0	11.8
2015	7	11	6	16	52	32	0	0	0	0	0	0	0	65.26	0	0	11.8
2015	7	11	6	26	52	32	0	0	0	0	0	0	0	65.21	0	0	11.8
2015	7	11	6	36	52	31	0	0	0	0	0	0	0	65.16	0	0	11.8
2015	7	11	6	46	52	32	0	0	0	0	0	0	0	65.12	0	0	11.8
2015	7	11	6	56	52	32	0	0	0	0	0	0	0	65.26	0	0	12.2
2015	7	11	7	6	52	31	0	0	0	0	0	0	0	65.32	0	0	12.2
2015	7	11	7	16	52	32	0	0	0	0	0	0	0	65.41	0	0	12.4
2015	7	11	7	26	52	31	0	0	0	0	0	0	0	65.48	0	0	12.6
2015	7	11	7	36	52	32	0	0	0	0	0	0	0	65.55	0	0	12.6
2015	7	11	7	46	52	32	0	0	0	0	0	0	0	65.61	0	0	12.8
2015	7	11	7	56	52	32	0	0	0	0	0	0	0	65.7	0	0	12.8
2015	7	11	8	6	52	32	0	0	0	0	0	0	0	65.82	0	0	13
2015	7	11	8	16	52	31	0	0	0	0	0	0	0	65.93	0	0	13
2015	7	11	8	26	52	31	0	0	0	0	0	0	0	66.07	0	0	13
2015	7	11	8	36	52	31	0	0	0	0	0	0	0	66.2	0	0	13.2
2015	7	11	8	46	52	32	0	0	0	0	0	0	0	66.31	0	0	13.2
2015	7	11	8	56	52	31	0	0	0	0	0	0	0	66.47	0	0	13.2
2015	7	11	9	6	52	30	0	0	0	0	0	0	0	66.63	0	0	13.2
2015	7	11	9	16	52	32	0	0	0	0	0	0	0	66.78	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	11	9	26	52	32	0	0	0	0	0	0	0	66.88	0	0	13.4
2015	7	11	9	36	52	32	0	0	0	0	0	0	0	67.06	0	0	13.4
2015	7	11	9	46	52	31	0	0	0	0	0	0	0	67.21	0	0	13.4
2015	7	11	9	56	52	32	0	0	0	0	0	0	0	67.39	0	0	13.4
2015	7	11	10	6	52	31	0	0	0	0	0	0	0	67.57	0	0	13.4
2015	7	11	10	16	52	31	0	0	0	0	0	0	0	67.75	0	0	13.4
2015	7	11	10	26	52	31	0	0	0	0	0	0	0	68	0	0	13.4
2015	7	11	10	36	52	31	0	0	0	0	0	0	0	68.18	0	0	13.4
2015	7	11	10	46	52	32	0	0	0	0	0	0	0	68.4	0	0	13.4
2015	7	11	10	56	52	31	0	0	0	0	0	0	0	68.54	0	0	13.4
2015	7	11	11	6	52	31	0	0	0	0	0	0	0	68.76	0	0	13.4
2015	7	11	11	16	52	31	0	0	0	0	0	0	0	68.95	0	0	13.4
2015	7	11	11	26	52	31	0	0	0	0	0	0	0	69.1	0	0	13.4
2015	7	11	11	36	52	31	0	0	0	0	0	0	0	69.35	0	0	13.4
2015	7	11	11	46	52	31	0	0	0	0	0	0	0	69.51	0	0	13.4
2015	7	11	11	56	52	31	0	0	0	0	0	0	0	68.63	0	0	13.4
2015	7	11	12	6	52	32	0	0	0	0	0	0	0	68.65	0	0	13.4
2015	7	11	12	16	52	32	0	0	0	0	0	0	0	68.85	0	0	13.4
2015	7	11	12	26	52	31	0	0	0	0	0	0	0	69.1	0	0	13.4
2015	7	11	12	36	52	31	0	0	0	0	0	0	0	69.33	0	0	13.4
2015	7	11	12	46	52	32	0	0	0	0	0	0	0	69.6	0	0	13.4
2015	7	11	12	56	52	32	0	0	0	0	0	0	0	69.94	0	0	13.4
2015	7	11	13	6	52	32	0	0	0	0	0	0	0	70.27	0	0	13.2
2015	7	11	13	16	52	31	0	0	0	0	0	0	0	71.24	0	0	13.4
2015	7	11	13	26	52	31	0	0	0	0	0	0	0	72.05	0	0	13.4
2015	7	11	13	36	52	32	0	0	0	0	0	0	0	72.55	0	0	13.4
2015	7	11	13	46	52	31	0	0	0	0	0	0	0	72.72	0	0	13.2
2015	7	11	13	56	52	31	0	0	0	0	0	0	0	72.72	0	0	13.2
2015	7	11	14	6	52	31	0	0	0	0	0	0	0	73.06	0	0	13
2015	7	11	14	16	52	30	0	0	0	0	0	0	0	72.82	0	0	12.8
2015	7	11	14	26	52	31	0	0	0	0	0	0	0	72.84	0	0	12.8
2015	7	11	14	36	52	31	0	0	0	0	0	0	0	72.97	0	0	12.8
2015	7	11	14	46	52	31	0	0	0	0	0	0	0	73.09	0	0	13
2015	7	11	14	56	52	31	0	0	0	0	0	0	0	73.78	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	11	15	6	52	30	0	0	0	0	0	0	0	73.94	0	0	13.2
2015	7	11	15	16	52	31	0	0	0	0	0	0	0	73.94	0	0	13.2
2015	7	11	15	26	52	31	0	0	0	0	0	0	0	74.08	0	0	13.2
2015	7	11	15	36	52	31	0	0	0	0	0	0	0	74.21	0	0	13.2
2015	7	11	15	46	52	31	0	0	0	0	0	0	0	74.23	0	0	13
2015	7	11	15	56	52	31	0	0	0	0	0	0	0	74.61	0	0	13.2
2015	7	11	16	6	52	31	0	0	0	0	0	0	0	74.66	0	0	13
2015	7	11	16	16	52	31	0	0	0	0	0	0	0	74.59	0	0	12.8
2015	7	11	16	26	52	31	0	0	0	0	0	0	0	74.8	0	0	13
2015	7	11	16	36	52	31	0	0	0	0	0	0	0	74.98	0	0	12.8
2015	7	11	16	46	52	30	0	0	0	0	0	0	0	74.84	0	0	12.6
2015	7	11	16	56	52	31	0	0	0	0	0	0	0	74.79	0	0	12.4
2015	7	11	17	6	52	31	0	0	0	0	0	0	0	74.84	0	0	12.4
2015	7	11	17	16	52	30	0	0	0	0	0	0	0	74.84	0	0	12.4
2015	7	11	17	26	52	30	0	0	0	0	0	0	0	74.79	0	0	12.4
2015	7	11	17	36	52	30	0	0	0	0	0	0	0	74.66	0	0	12.4
2015	7	11	17	46	52	31	0	0	0	0	0	0	0	74.64	0	0	12.4
2015	7	11	17	56	52	30	0	0	0	0	0	0	0	74.62	0	0	12.2
2015	7	11	18	6	52	31	0	0	0	0	0	0	0	74.61	0	0	12.2
2015	7	11	18	16	52	30	0	0	0	0	0	0	0	74.64	0	0	12.2
2015	7	11	18	26	52	31	0	0	0	0	0	0	0	74.68	0	0	12.2
2015	7	11	18	36	52	31	0	0	0	0	0	0	0	74.57	0	0	12.2
2015	7	11	18	46	52	30	0	0	0	0	0	0	0	74.52	0	0	12.2
2015	7	11	18	56	52	31	0	0	0	0	0	0	0	74.48	0	0	12.2
2015	7	11	19	6	52	30	0	0	0	0	0	0	0	74.46	0	0	12.2
2015	7	11	19	16	52	30	0	0	0	0	0	0	0	74.43	0	0	12.2
2015	7	11	19	26	52	31	0	0	0	0	0	0	0	74.41	0	0	12.2
2015	7	11	19	36	52	31	0	0	0	0	0	0	0	74.39	0	0	12.2
2015	7	11	19	46	52	31	0	0	0	0	0	0	0	74.35	0	0	12.2
2015	7	11	19	56	52	30	0	0	0	0	0	0	0	74.3	0	0	12.2
2015	7	11	20	6	52	30	0	0	0	0	0	0	0	74.26	0	0	12.2
2015	7	11	20	16	52	30	0	0	0	0	0	0	0	74.21	0	0	12.2
2015	7	11	20	26	52	31	0	0	0	0	0	0	0	74.16	0	0	12.2
2015	7	11	20	36	52	31	0	0	0	0	0	0	0	74.08	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	11	20	46	52	30	0	0	0	0	0	0	0	73.99	0	0	12.2
2015	7	11	20	56	52	31	0	0	0	0	0	0	0	73.9	0	0	12
2015	7	11	21	6	52	31	0	0	0	0	0	0	0	73.81	0	0	12
2015	7	11	21	16	52	31	0	0	0	0	0	0	0	73.72	0	0	12
2015	7	11	21	26	52	31	0	0	0	0	0	0	0	73.63	0	0	12
2015	7	11	21	36	52	31	0	0	0	0	0	0	0	73.54	0	0	12
2015	7	11	21	46	52	31	0	0	0	0	0	0	0	73.44	0	0	12
2015	7	11	21	56	52	30	0	0	0	0	0	0	0	73.33	0	0	12
2015	7	11	22	6	52	31	0	0	0	0	0	0	0	73.2	0	0	12
2015	7	11	22	16	52	30	0	0	0	0	0	0	0	73.08	0	0	12
2015	7	11	22	26	52	30	0	0	0	0	0	0	0	72.95	0	0	12
2015	7	11	22	36	52	30	0	0	0	0	0	0	0	72.81	0	0	12
2015	7	11	22	46	52	31	0	0	0	0	0	0	0	72.66	0	0	12
2015	7	11	22	56	52	31	0	0	0	0	0	0	0	72.54	0	0	12
2015	7	11	23	6	52	31	0	0	0	0	0	0	0	72.37	0	0	12
2015	7	11	23	16	52	30	0	0	0	0	0	0	0	72.23	0	0	12
2015	7	11	23	26	52	31	0	0	0	0	0	0	0	72.07	0	0	12
2015	7	11	23	36	52	31	0	0	0	0	0	0	0	71.89	0	0	12
2015	7	11	23	46	52	32	0	0	0	0	0	0	0	71.73	0	0	12
2015	7	11	23	56	52	30	0	0	0	0	0	0	0	71.56	0	0	12
2015	7	12	0	6	52	31	0	0	0	0	0	0	0	71.42	0	0	12
2015	7	12	0	16	52	31	0	0	0	0	0	0	0	71.24	0	0	12
2015	7	12	0	26	52	31	0	0	0	0	0	0	0	71.08	0	0	12
2015	7	12	0	36	52	31	0	0	0	0	0	0	0	70.93	0	0	12
2015	7	12	0	46	52	31	0	0	0	0	0	0	0	70.75	0	0	12
2015	7	12	0	56	52	31	0	0	0	0	0	0	0	70.63	0	0	12
2015	7	12	1	6	52	31	0	0	0	0	0	0	0	70.48	0	0	12
2015	7	12	1	16	52	31	0	0	0	0	0	0	0	70.34	0	0	12
2015	7	12	1	26	52	31	0	0	0	0	0	0	0	70.21	0	0	12
2015	7	12	1	36	52	31	0	0	0	0	0	0	0	70.07	0	0	12
2015	7	12	1	46	52	32	0	0	0	0	0	0	0	69.93	0	0	12
2015	7	12	1	56	52	31	0	0	0	0	0	0	0	69.8	0	0	12
2015	7	12	2	6	52	32	0	0	0	0	0	0	0	69.67	0	0	12
2015	7	12	2	16	52	31	0	0	0	0	0	0	0	69.57	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	12	2	26	52	31	0	0	0	0	0	0	0	69.44	0	0	12
2015	7	12	2	36	52	30	0	0	0	0	0	0	0	69.31	0	0	12
2015	7	12	2	46	52	31	0	0	0	0	0	0	0	69.19	0	0	12
2015	7	12	2	56	52	31	0	0	0	0	0	0	0	69.08	0	0	12
2015	7	12	3	6	52	31	0	0	0	0	0	0	0	68.94	0	0	12
2015	7	12	3	16	52	32	0	0	0	0	0	0	0	68.81	0	0	12
2015	7	12	3	26	52	32	0	0	0	0	0	0	0	68.7	0	0	12
2015	7	12	3	36	52	31	0	0	0	0	0	0	0	68.58	0	0	12
2015	7	12	3	46	52	32	0	0	0	0	0	0	0	68.47	0	0	12
2015	7	12	3	56	52	31	0	0	0	0	0	0	0	68.36	0	0	12
2015	7	12	4	6	52	31	0	0	0	0	0	0	0	68.25	0	0	12
2015	7	12	4	16	52	31	0	0	0	0	0	0	0	68.13	0	0	12
2015	7	12	4	26	52	32	0	0	0	0	0	0	0	68.02	0	0	12
2015	7	12	4	36	52	31	0	0	0	0	0	0	0	67.89	0	0	12
2015	7	12	4	46	52	31	0	0	0	0	0	0	0	67.8	0	0	12
2015	7	12	4	56	52	32	0	0	0	0	0	0	0	67.69	0	0	12
2015	7	12	5	6	52	31	0	0	0	0	0	0	0	67.59	0	0	12
2015	7	12	5	16	52	31	0	0	0	0	0	0	0	67.5	0	0	12
2015	7	12	5	26	52	31	0	0	0	0	0	0	0	67.37	0	0	12
2015	7	12	5	36	52	31	0	0	0	0	0	0	0	67.24	0	0	12
2015	7	12	5	46	52	31	0	0	0	0	0	0	0	67.15	0	0	12
2015	7	12	5	56	52	31	0	0	0	0	0	0	0	67.06	0	0	12
2015	7	12	6	6	52	31	0	0	0	0	0	0	0	66.97	0	0	12
2015	7	12	6	16	52	31	0	0	0	0	0	0	0	66.88	0	0	12
2015	7	12	6	26	52	31	0	0	0	0	0	0	0	66.81	0	0	12
2015	7	12	6	36	52	32	0	0	0	0	0	0	0	66.74	0	0	12
2015	7	12	6	46	52	31	0	0	0	0	0	0	0	66.67	0	0	12
2015	7	12	6	56	52	31	0	0	0	0	0	0	0	66.85	0	0	12.2
2015	7	12	7	6	52	31	0	0	0	0	0	0	0	66.92	0	0	12.2
2015	7	12	7	16	52	31	0	0	0	0	0	0	0	67.01	0	0	12.4
2015	7	12	7	26	52	31	0	0	0	0	0	0	0	67.12	0	0	12.6
2015	7	12	7	36	52	31	0	0	0	0	0	0	0	67.19	0	0	12.6
2015	7	12	7	46	52	31	0	0	0	0	0	0	0	67.32	0	0	12.8
2015	7	12	7	56	52	32	0	0	0	0	0	0	0	67.35	0	0	13

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	12	8	6	52	31	0	0	0	0	0	0	0	67.5	0	0	13
2015	7	12	8	16	52	31	0	0	0	0	0	0	0	67.68	0	0	13
2015	7	12	8	26	52	32	0	0	0	0	0	0	0	67.8	0	0	13
2015	7	12	8	36	52	31	0	0	0	0	0	0	0	67.91	0	0	13.2
2015	7	12	8	46	52	31	0	0	0	0	0	0	0	68.09	0	0	13.2
2015	7	12	8	56	52	32	0	0	0	0	0	0	0	68.25	0	0	13.2
2015	7	12	9	6	52	31	0	0	0	0	0	0	0	68.41	0	0	13.2
2015	7	12	9	16	52	31	0	0	0	0	0	0	0	68.54	0	0	13.2
2015	7	12	9	26	52	31	0	0	0	0	0	0	0	68.7	0	0	13.2
2015	7	12	9	36	52	32	0	0	0	0	0	0	0	68.61	0	0	13.2
2015	7	12	9	46	52	30	0	0	0	0	0	0	0	68.68	0	0	13
2015	7	12	9	56	52	31	0	0	0	0	0	0	0	69.17	0	0	13.2
2015	7	12	10	6	52	31	0	0	0	0	0	0	0	69.35	0	0	13.2
2015	7	12	10	16	52	31	0	0	0	0	0	0	0	69.55	0	0	13.4
2015	7	12	10	26	52	31	0	0	0	0	0	0	0	69.4	0	0	13.2
2015	7	12	10	36	52	31	0	0	0	0	0	0	0	69.48	0	0	13.2
2015	7	12	10	46	52	31	0	0	0	0	0	0	0	69.89	0	0	13.4
2015	7	12	10	56	52	31	0	0	0	0	0	0	0	70.16	0	0	13.2
2015	7	12	11	6	52	31	0	0	0	0	0	0	0	69.84	0	0	13
2015	7	12	11	16	52	31	0	0	0	0	0	0	0	70.57	0	0	13.4
2015	7	12	11	26	52	30	0	0	0	0	0	0	0	70.97	0	0	13.4
2015	7	12	11	36	52	31	0	0	0	0	0	0	0	70.75	0	0	13.2
2015	7	12	11	46	52	30	0	0	0	0	0	0	0	70.32	0	0	13.2
2015	7	12	11	56	52	31	0	0	0	0	0	0	0	70.3	0	0	13.4
2015	7	12	12	6	52	31	0	0	0	0	0	0	0	70.29	0	0	13.2
2015	7	12	12	16	52	31	0	0	0	0	0	0	0	70.21	0	0	13.2
2015	7	12	12	26	52	31	0	0	0	0	0	0	0	70.38	0	0	13.4
2015	7	12	12	36	52	32	0	0	0	0	0	0	0	70.45	0	0	13.4
2015	7	12	12	46	52	31	0	0	0	0	0	0	0	70.61	0	0	13.4
2015	7	12	12	56	52	31	0	0	0	0	0	0	0	70.88	0	0	13.2
2015	7	12	13	6	52	31	0	0	0	0	0	0	0	71.13	0	0	13.2
2015	7	12	13	16	52	31	0	0	0	0	0	0	0	72.16	0	0	13.2
2015	7	12	13	26	52	31	0	0	0	0	0	0	0	72.88	0	0	13.2
2015	7	12	13	36	52	31	0	0	0	0	0	0	0	73.27	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	12	13	46	52	31	0	0	0	0	0	0	0	73.63	0	0	13.2
2015	7	12	13	56	52	30	0	0	0	0	0	0	0	73.83	0	0	13.2
2015	7	12	14	6	52	31	0	0	0	0	0	0	0	74.3	0	0	13.2
2015	7	12	14	16	52	30	0	0	0	0	0	0	0	74.53	0	0	13.2
2015	7	12	14	26	52	30	0	0	0	0	0	0	0	74.77	0	0	13.2
2015	7	12	14	36	52	31	0	0	0	0	0	0	0	75.02	0	0	13.2
2015	7	12	14	46	52	31	0	0	0	0	0	0	0	75.18	0	0	13.2
2015	7	12	14	56	52	31	0	0	0	0	0	0	0	75.4	0	0	13.2
2015	7	12	15	6	52	31	0	0	0	0	0	0	0	75.45	0	0	13.2
2015	7	12	15	16	52	31	0	0	0	0	0	0	0	75.7	0	0	13.2
2015	7	12	15	26	52	31	0	0	0	0	0	0	0	75.85	0	0	13.2
2015	7	12	15	36	52	31	0	0	0	0	0	0	0	75.97	0	0	13.2
2015	7	12	15	46	52	31	0	0	0	0	0	0	0	76.12	0	0	13.2
2015	7	12	15	56	52	30	0	0	0	0	0	0	0	76.21	0	0	13
2015	7	12	16	6	52	31	0	0	0	0	0	0	0	76.24	0	0	13
2015	7	12	16	16	52	30	0	0	0	0	0	0	0	76.32	0	0	12.8
2015	7	12	16	26	52	31	0	0	0	0	0	0	0	76.41	0	0	12.8
2015	7	12	16	36	52	31	0	0	0	0	0	0	0	76.46	0	0	12.6
2015	7	12	16	46	52	30	0	0	0	0	0	0	0	76.51	0	0	12.6
2015	7	12	16	56	52	30	0	0	0	0	0	0	0	76.55	0	0	12.4
2015	7	12	17	6	52	30	0	0	0	0	0	0	0	76.59	0	0	12.4
2015	7	12	17	16	52	30	0	0	0	0	0	0	0	76.57	0	0	12.4
2015	7	12	17	26	52	30	0	0	0	0	0	0	0	76.5	0	0	12.2
2015	7	12	17	36	52	30	0	0	0	0	0	0	0	76.39	0	0	12.2
2015	7	12	17	46	52	30	0	0	0	0	0	0	0	76.26	0	0	12.2
2015	7	12	17	56	52	30	0	0	0	0	0	0	0	76.19	0	0	12.2
2015	7	12	18	6	52	30	0	0	0	0	0	0	0	76.15	0	0	12.2
2015	7	12	18	16	52	30	0	0	0	0	0	0	0	76.14	0	0	12.2
2015	7	12	18	26	52	31	0	0	0	0	0	0	0	76.12	0	0	12.2
2015	7	12	18	36	52	31	0	0	0	0	0	0	0	76.1	0	0	12.2
2015	7	12	18	46	52	30	0	0	0	0	0	0	0	76.08	0	0	12.2
2015	7	12	18	56	52	31	0	0	0	0	0	0	0	76.06	0	0	12.2
2015	7	12	19	6	52	30	0	0	0	0	0	0	0	76.01	0	0	12.2
2015	7	12	19	16	52	30	0	0	0	0	0	0	0	75.96	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	12	19	26	52	30	0	0	0	0	0	0	0	75.88	0	0	12.2
2015	7	12	19	36	52	30	0	0	0	0	0	0	0	75.83	0	0	12.2
2015	7	12	19	46	52	30	0	0	0	0	0	0	0	75.76	0	0	12.2
2015	7	12	19	56	52	30	0	0	0	0	0	0	0	75.69	0	0	12.2
2015	7	12	20	6	52	31	0	0	0	0	0	0	0	75.61	0	0	12.2
2015	7	12	20	16	52	31	0	0	0	0	0	0	0	75.54	0	0	12.2
2015	7	12	20	26	52	30	0	0	0	0	0	0	0	75.49	0	0	12.2
2015	7	12	20	36	52	31	0	0	0	0	0	0	0	75.42	0	0	12.2
2015	7	12	20	46	52	31	0	0	0	0	0	0	0	75.36	0	0	12.2
2015	7	12	20	56	52	31	0	0	0	0	0	0	0	75.29	0	0	12.2
2015	7	12	21	6	52	30	0	0	0	0	0	0	0	75.2	0	0	12.2
2015	7	12	21	16	52	30	0	0	0	0	0	0	0	75.11	0	0	12
2015	7	12	21	26	52	30	0	0	0	0	0	0	0	75.04	0	0	12
2015	7	12	21	36	52	30	0	0	0	0	0	0	0	74.93	0	0	12
2015	7	12	21	46	52	31	0	0	0	0	0	0	0	74.8	0	0	12
2015	7	12	21	56	52	30	0	0	0	0	0	0	0	74.66	0	0	12
2015	7	12	22	6	52	31	0	0	0	0	0	0	0	74.53	0	0	12
2015	7	12	22	16	52	30	0	0	0	0	0	0	0	74.39	0	0	12
2015	7	12	22	26	52	31	0	0	0	0	0	0	0	74.25	0	0	12
2015	7	12	22	36	52	30	0	0	0	0	0	0	0	74.08	0	0	12
2015	7	12	22	46	52	31	0	0	0	0	0	0	0	73.92	0	0	12
2015	7	12	22	56	52	31	0	0	0	0	0	0	0	73.74	0	0	12
2015	7	12	23	6	52	31	0	0	0	0	0	0	0	73.58	0	0	12
2015	7	12	23	16	52	30	0	0	0	0	0	0	0	73.4	0	0	12
2015	7	12	23	26	52	31	0	0	0	0	0	0	0	73.24	0	0	12
2015	7	12	23	36	52	30	0	0	0	0	0	0	0	73.08	0	0	12
2015	7	12	23	46	52	30	0	0	0	0	0	0	0	72.91	0	0	12
2015	7	12	23	56	52	31	0	0	0	0	0	0	0	72.77	0	0	12
2015	7	13	0	6	52	30	0	0	0	0	0	0	0	72.61	0	0	12
2015	7	13	0	16	52	30	0	0	0	0	0	0	0	72.45	0	0	12
2015	7	13	0	26	52	31	0	0	0	0	0	0	0	72.28	0	0	12
2015	7	13	0	36	52	31	0	0	0	0	0	0	0	72.1	0	0	12
2015	7	13	0	46	52	31	0	0	0	0	0	0	0	71.94	0	0	12
2015	7	13	0	56	52	31	0	0	0	0	0	0	0	71.78	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	13	1	6	52	30	0	0	0	0	0	0	0	71.62	0	0	12
2015	7	13	1	16	52	31	0	0	0	0	0	0	0	71.44	0	0	12
2015	7	13	1	26	52	30	0	0	0	0	0	0	0	71.26	0	0	12
2015	7	13	1	36	52	31	0	0	0	0	0	0	0	71.08	0	0	12
2015	7	13	1	46	52	30	0	0	0	0	0	0	0	70.92	0	0	12
2015	7	13	1	56	52	31	0	0	0	0	0	0	0	70.75	0	0	12
2015	7	13	2	6	52	31	0	0	0	0	0	0	0	70.63	0	0	12
2015	7	13	2	16	52	30	0	0	0	0	0	0	0	70.48	0	0	12
2015	7	13	2	26	52	31	0	0	0	0	0	0	0	70.34	0	0	12
2015	7	13	2	36	52	31	0	0	0	0	0	0	0	70.23	0	0	12
2015	7	13	2	46	52	30	0	0	0	0	0	0	0	70.11	0	0	12
2015	7	13	2	56	52	31	0	0	0	0	0	0	0	69.98	0	0	12
2015	7	13	3	6	52	31	0	0	0	0	0	0	0	69.87	0	0	12
2015	7	13	3	16	52	32	0	0	0	0	0	0	0	69.78	0	0	12
2015	7	13	3	26	52	30	0	0	0	0	0	0	0	69.69	0	0	12
2015	7	13	3	36	52	31	0	0	0	0	0	0	0	69.6	0	0	12
2015	7	13	3	46	52	31	0	0	0	0	0	0	0	69.51	0	0	12
2015	7	13	3	56	52	31	0	0	0	0	0	0	0	69.44	0	0	12
2015	7	13	4	6	52	31	0	0	0	0	0	0	0	69.35	0	0	12
2015	7	13	4	16	52	31	0	0	0	0	0	0	0	69.26	0	0	12
2015	7	13	4	26	52	32	0	0	0	0	0	0	0	69.19	0	0	12
2015	7	13	4	36	52	31	0	0	0	0	0	0	0	69.12	0	0	12
2015	7	13	4	46	52	31	0	0	0	0	0	0	0	69.04	0	0	12
2015	7	13	4	56	52	31	0	0	0	0	0	0	0	68.97	0	0	12
2015	7	13	5	6	52	31	0	0	0	0	0	0	0	68.9	0	0	12
2015	7	13	5	16	52	31	0	0	0	0	0	0	0	68.83	0	0	12
2015	7	13	5	26	52	31	0	0	0	0	0	0	0	68.76	0	0	12
2015	7	13	5	36	52	31	0	0	0	0	0	0	0	68.7	0	0	12
2015	7	13	5	46	52	30	0	0	0	0	0	0	0	68.67	0	0	12
2015	7	13	5	56	52	31	0	0	0	0	0	0	0	68.63	0	0	12
2015	7	13	6	6	52	30	0	0	0	0	0	0	0	68.58	0	0	12
2015	7	13	6	16	52	32	0	0	0	0	0	0	0	68.54	0	0	12
2015	7	13	6	26	52	32	0	0	0	0	0	0	0	68.5	0	0	12
2015	7	13	6	36	52	31	0	0	0	0	0	0	0	68.5	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	13	6	46	52	31	0	0	0	0	0	0	0	68.5	0	0	12
2015	7	13	6	56	52	31	0	0	0	0	0	0	0	68.52	0	0	12
2015	7	13	7	6	52	32	0	0	0	0	0	0	0	68.61	0	0	12.2
2015	7	13	7	16	52	31	0	0	0	0	0	0	0	68.63	0	0	12.2
2015	7	13	7	26	52	31	0	0	0	0	0	0	0	68.58	0	0	12.2
2015	7	13	7	36	52	32	0	0	0	0	0	0	0	68.59	0	0	12.2
2015	7	13	7	46	52	31	0	0	0	0	0	0	0	68.72	0	0	12.2
2015	7	13	7	56	52	31	0	0	0	0	0	0	0	68.83	0	0	12.4
2015	7	13	8	6	52	31	0	0	0	0	0	0	0	68.94	0	0	12.4
2015	7	13	8	16	52	31	0	0	0	0	0	0	0	68.95	0	0	12.6
2015	7	13	8	26	52	30	0	0	0	0	0	0	0	68.99	0	0	12.6
2015	7	13	8	36	52	31	0	0	0	0	0	0	0	68.81	0	0	12.4
2015	7	13	8	46	52	32	0	0	0	0	0	0	0	69.28	0	0	12.8
2015	7	13	8	56	52	31	0	0	0	0	0	0	0	69.94	0	0	13.2
2015	7	13	9	6	52	31	0	0	0	0	0	0	0	70.11	0	0	13.2
2015	7	13	9	16	52	31	0	0	0	0	0	0	0	70.27	0	0	13.2
2015	7	13	9	26	52	31	0	0	0	0	0	0	0	70.48	0	0	13.2
2015	7	13	9	36	52	31	0	0	0	0	0	0	0	70.59	0	0	13.2
2015	7	13	9	46	52	32	0	0	0	0	0	0	0	70.79	0	0	13.2
2015	7	13	9	56	52	31	0	0	0	0	0	0	0	70.97	0	0	13.2
2015	7	13	10	6	52	30	0	0	0	0	0	0	0	71.13	0	0	13.2
2015	7	13	10	16	52	31	0	0	0	0	0	0	0	71.33	0	0	13.2
2015	7	13	10	26	52	30	0	0	0	0	0	0	0	71.46	0	0	13.2
2015	7	13	10	36	52	31	0	0	0	0	0	0	0	71.65	0	0	13.2
2015	7	13	10	46	52	31	0	0	0	0	0	0	0	71.91	0	0	13.2
2015	7	13	10	56	52	31	0	0	0	0	0	0	0	71.96	0	0	13.2
2015	7	13	11	6	52	30	0	0	0	0	0	0	0	72.25	0	0	13.2
2015	7	13	11	16	52	31	0	0	0	0	0	0	0	72.46	0	0	13.2
2015	7	13	11	26	52	30	0	0	0	0	0	0	0	72.68	0	0	13.2
2015	7	13	11	36	52	30	0	0	0	0	0	0	0	72.88	0	0	13.2
2015	7	13	11	46	52	30	0	0	0	0	0	0	0	72.93	0	0	13.2
2015	7	13	11	56	52	31	0	0	0	0	0	0	0	72	0	0	13.2
2015	7	13	12	6	52	31	0	0	0	0	0	0	0	71.98	0	0	13.2
2015	7	13	12	16	52	31	0	0	0	0	0	0	0	72.12	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	13	12	26	52	31	0	0	0	0	0	0	0	72.34	0	0	13.2
2015	7	13	12	36	52	30	0	0	0	0	0	0	0	72.61	0	0	13.2
2015	7	13	12	46	52	31	0	0	0	0	0	0	0	72.88	0	0	13.2
2015	7	13	12	56	52	31	0	0	0	0	0	0	0	73.15	0	0	13.2
2015	7	13	13	6	52	31	0	0	0	0	0	0	0	73.51	0	0	13.2
2015	7	13	13	16	52	31	0	0	0	0	0	0	0	74.61	0	0	13.2
2015	7	13	13	26	52	30	0	0	0	0	0	0	0	75.42	0	0	13.2
2015	7	13	13	36	52	30	0	0	0	0	0	0	0	75.85	0	0	13.2
2015	7	13	13	46	52	30	0	0	0	0	0	0	0	76.15	0	0	13.2
2015	7	13	13	56	52	31	0	0	0	0	0	0	0	76.33	0	0	13.2
2015	7	13	14	6	52	30	0	0	0	0	0	0	0	76.51	0	0	13.2
2015	7	13	14	16	52	30	0	0	0	0	0	0	0	76.86	0	0	13.2
2015	7	13	14	26	52	31	0	0	0	0	0	0	0	77.11	0	0	13.2
2015	7	13	14	36	52	30	0	0	0	0	0	0	0	77.32	0	0	13.2
2015	7	13	14	46	52	30	0	0	0	0	0	0	0	77.49	0	0	13.2
2015	7	13	14	56	52	31	0	0	0	0	0	0	0	77.72	0	0	13.2
2015	7	13	15	6	52	31	0	0	0	0	0	0	0	77.88	0	0	13.2
2015	7	13	15	16	52	30	0	0	0	0	0	0	0	77.86	0	0	13.2
2015	7	13	15	26	52	30	0	0	0	0	0	0	0	78.04	0	0	13.2
2015	7	13	15	36	52	30	0	0	0	0	0	0	0	78.15	0	0	13
2015	7	13	15	46	52	30	0	0	0	0	0	0	0	78.28	0	0	13
2015	7	13	15	56	52	30	0	0	0	0	0	0	0	78.37	0	0	13
2015	7	13	16	6	52	30	0	0	0	0	0	0	0	78.44	0	0	13
2015	7	13	16	16	52	30	0	0	0	0	0	0	0	78.49	0	0	13
2015	7	13	16	26	52	31	0	0	0	0	0	0	0	78.55	0	0	12.8
2015	7	13	16	36	52	31	0	0	0	0	0	0	0	78.62	0	0	12.8
2015	7	13	16	46	52	30	0	0	0	0	0	0	0	78.69	0	0	12.8
2015	7	13	16	56	52	30	0	0	0	0	0	0	0	78.67	0	0	12.6
2015	7	13	17	6	52	30	0	0	0	0	0	0	0	78.71	0	0	12.6
2015	7	13	17	16	52	30	0	0	0	0	0	0	0	78.58	0	0	12.4
2015	7	13	17	26	52	31	0	0	0	0	0	0	0	78.44	0	0	12.4
2015	7	13	17	36	52	30	0	0	0	0	0	0	0	78.42	0	0	12.4
2015	7	13	17	46	52	30	0	0	0	0	0	0	0	78.39	0	0	12.4
2015	7	13	17	56	52	30	0	0	0	0	0	0	0	78.31	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	13	18	6	52	30	0	0	0	0	0	0	0	78.28	0	0	12.2
2015	7	13	18	16	52	30	0	0	0	0	0	0	0	78.22	0	0	12.2
2015	7	13	18	26	52	30	0	0	0	0	0	0	0	78.21	0	0	12.2
2015	7	13	18	36	52	30	0	0	0	0	0	0	0	78.19	0	0	12.2
2015	7	13	18	46	52	30	0	0	0	0	0	0	0	78.15	0	0	12.2
2015	7	13	18	56	52	30	0	0	0	0	0	0	0	78.04	0	0	12.2
2015	7	13	19	6	52	30	0	0	0	0	0	0	0	77.99	0	0	12.2
2015	7	13	19	16	52	30	0	0	0	0	0	0	0	77.95	0	0	12.2
2015	7	13	19	26	52	30	0	0	0	0	0	0	0	77.9	0	0	12.2
2015	7	13	19	36	52	30	0	0	0	0	0	0	0	77.85	0	0	12.2
2015	7	13	19	46	52	32	0	0	0	0	0	0	0	77.79	0	0	12.2
2015	7	13	19	56	52	30	0	0	0	0	0	0	0	77.76	0	0	12.2
2015	7	13	20	6	52	30	0	0	0	0	0	0	0	77.7	0	0	12.2
2015	7	13	20	16	52	30	0	0	0	0	0	0	0	77.63	0	0	12.2
2015	7	13	20	26	52	30	0	0	0	0	0	0	0	77.56	0	0	12.2
2015	7	13	20	36	52	30	0	0	0	0	0	0	0	77.5	0	0	12.2
2015	7	13	20	46	52	30	0	0	0	0	0	0	0	77.41	0	0	12.2
2015	7	13	20	56	52	30	0	0	0	0	0	0	0	77.32	0	0	12.2
2015	7	13	21	6	52	30	0	0	0	0	0	0	0	77.2	0	0	12.2
2015	7	13	21	16	52	31	0	0	0	0	0	0	0	77.07	0	0	12.2
2015	7	13	21	26	52	30	0	0	0	0	0	0	0	76.95	0	0	12
2015	7	13	21	36	52	30	0	0	0	0	0	0	0	76.82	0	0	12
2015	7	13	21	46	52	30	0	0	0	0	0	0	0	76.68	0	0	12
2015	7	13	21	56	52	30	0	0	0	0	0	0	0	76.55	0	0	12
2015	7	13	22	6	52	30	0	0	0	0	0	0	0	76.39	0	0	12
2015	7	13	22	16	52	30	0	0	0	0	0	0	0	76.24	0	0	12
2015	7	13	22	26	52	30	0	0	0	0	0	0	0	76.08	0	0	12
2015	7	13	22	36	52	30	0	0	0	0	0	0	0	75.92	0	0	12
2015	7	13	22	46	52	30	0	0	0	0	0	0	0	75.78	0	0	12
2015	7	13	22	56	52	31	0	0	0	0	0	0	0	75.6	0	0	12
2015	7	13	23	6	52	30	0	0	0	0	0	0	0	75.43	0	0	12
2015	7	13	23	16	52	30	0	0	0	0	0	0	0	75.29	0	0	12
2015	7	13	23	26	52	30	0	0	0	0	0	0	0	75.15	0	0	12
2015	7	13	23	36	52	31	0	0	0	0	0	0	0	74.97	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	13	23	46	52	30	0	0	0	0	0	0	0	74.79	0	0	12
2015	7	13	23	56	52	30	0	0	0	0	0	0	0	74.61	0	0	12
2015	7	14	0	6	52	31	0	0	0	0	0	0	0	74.46	0	0	12
2015	7	14	0	16	52	30	0	0	0	0	0	0	0	74.3	0	0	12
2015	7	14	0	26	52	30	0	0	0	0	0	0	0	74.12	0	0	12
2015	7	14	0	36	52	31	0	0	0	0	0	0	0	73.96	0	0	12
2015	7	14	0	46	52	30	0	0	0	0	0	0	0	73.8	0	0	12
2015	7	14	0	56	52	30	0	0	0	0	0	0	0	73.63	0	0	12
2015	7	14	1	6	52	31	0	0	0	0	0	0	0	73.45	0	0	12
2015	7	14	1	16	52	30	0	0	0	0	0	0	0	73.29	0	0	12
2015	7	14	1	26	52	30	0	0	0	0	0	0	0	73.15	0	0	12
2015	7	14	1	36	52	31	0	0	0	0	0	0	0	73	0	0	12
2015	7	14	1	46	52	30	0	0	0	0	0	0	0	72.84	0	0	12
2015	7	14	1	56	52	31	0	0	0	0	0	0	0	72.72	0	0	12
2015	7	14	2	6	52	31	0	0	0	0	0	0	0	72.57	0	0	12
2015	7	14	2	16	52	30	0	0	0	0	0	0	0	72.46	0	0	12
2015	7	14	2	26	52	31	0	0	0	0	0	0	0	72.34	0	0	12
2015	7	14	2	36	52	30	0	0	0	0	0	0	0	72.23	0	0	12
2015	7	14	2	46	52	31	0	0	0	0	0	0	0	72.14	0	0	12
2015	7	14	2	56	52	31	0	0	0	0	0	0	0	72.05	0	0	12
2015	7	14	3	6	52	31	0	0	0	0	0	0	0	71.96	0	0	12
2015	7	14	3	16	52	31	0	0	0	0	0	0	0	71.85	0	0	12
2015	7	14	3	26	52	30	0	0	0	0	0	0	0	71.74	0	0	12
2015	7	14	3	36	52	31	0	0	0	0	0	0	0	71.64	0	0	12
2015	7	14	3	46	52	30	0	0	0	0	0	0	0	71.53	0	0	12
2015	7	14	3	56	52	31	0	0	0	0	0	0	0	71.44	0	0	12
2015	7	14	4	6	52	30	0	0	0	0	0	0	0	71.33	0	0	12
2015	7	14	4	16	52	31	0	0	0	0	0	0	0	71.22	0	0	12
2015	7	14	4	26	52	31	0	0	0	0	0	0	0	71.11	0	0	12
2015	7	14	4	36	52	30	0	0	0	0	0	0	0	71.02	0	0	12
2015	7	14	4	46	52	31	0	0	0	0	0	0	0	70.92	0	0	12
2015	7	14	4	56	52	31	0	0	0	0	0	0	0	70.81	0	0	12
2015	7	14	5	6	52	31	0	0	0	0	0	0	0	70.72	0	0	12
2015	7	14	5	16	52	31	0	0	0	0	0	0	0	70.63	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	14	5	26	52	31	0	0	0	0	0	0	0	70.54	0	0	12
2015	7	14	5	36	52	31	0	0	0	0	0	0	0	70.43	0	0	12
2015	7	14	5	46	52	31	0	0	0	0	0	0	0	70.34	0	0	12
2015	7	14	5	56	52	31	0	0	0	0	0	0	0	70.25	0	0	12
2015	7	14	6	6	52	31	0	0	0	0	0	0	0	70.18	0	0	12
2015	7	14	6	16	52	31	0	0	0	0	0	0	0	70.07	0	0	12
2015	7	14	6	26	52	30	0	0	0	0	0	0	0	70	0	0	12
2015	7	14	6	36	52	31	0	0	0	0	0	0	0	69.93	0	0	12
2015	7	14	6	46	52	30	0	0	0	0	0	0	0	69.87	0	0	12
2015	7	14	6	56	52	30	0	0	0	0	0	0	0	70.03	0	0	12.2
2015	7	14	7	6	52	31	0	0	0	0	0	0	0	70.16	0	0	12.2
2015	7	14	7	16	52	31	0	0	0	0	0	0	0	70.23	0	0	12.4
2015	7	14	7	26	52	31	0	0	0	0	0	0	0	70.34	0	0	12.6
2015	7	14	7	36	52	31	0	0	0	0	0	0	0	70.43	0	0	12.6
2015	7	14	7	46	52	31	0	0	0	0	0	0	0	70.54	0	0	12.8
2015	7	14	7	56	52	31	0	0	0	0	0	0	0	70.68	0	0	13
2015	7	14	8	6	52	31	0	0	0	0	0	0	0	70.81	0	0	13
2015	7	14	8	16	52	31	0	0	0	0	0	0	0	70.92	0	0	13
2015	7	14	8	26	52	31	0	0	0	0	0	0	0	71.1	0	0	13
2015	7	14	8	36	52	31	0	0	0	0	0	0	0	71.2	0	0	13
2015	7	14	8	46	52	31	0	0	0	0	0	0	0	71.38	0	0	13.2
2015	7	14	8	56	52	31	0	0	0	0	0	0	0	71.46	0	0	13.2
2015	7	14	9	6	52	31	0	0	0	0	0	0	0	71.65	0	0	13.2
2015	7	14	9	16	52	30	0	0	0	0	0	0	0	71.89	0	0	13.2
2015	7	14	9	26	52	31	0	0	0	0	0	0	0	72.05	0	0	13.2
2015	7	14	9	36	52	31	0	0	0	0	0	0	0	72.21	0	0	13.2
2015	7	14	9	46	52	31	0	0	0	0	0	0	0	72.39	0	0	13.2
2015	7	14	9	56	52	31	0	0	0	0	0	0	0	72.5	0	0	13.2
2015	7	14	10	6	52	31	0	0	0	0	0	0	0	72.45	0	0	13.2
2015	7	14	10	16	52	30	0	0	0	0	0	0	0	72.59	0	0	13.2
2015	7	14	10	26	52	31	0	0	0	0	0	0	0	72.75	0	0	13.2
2015	7	14	10	36	52	31	0	0	0	0	0	0	0	72.95	0	0	13.2
2015	7	14	10	46	52	31	0	0	0	0	0	0	0	73.13	0	0	13.2
2015	7	14	10	56	52	31	0	0	0	0	0	0	0	73.35	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	14	11	6	52	31	0	0	0	0	0	0	0	73.51	0	0	13.2
2015	7	14	11	16	52	31	0	0	0	0	0	0	0	73.71	0	0	13.2
2015	7	14	11	26	52	30	0	0	0	0	0	0	0	73.94	0	0	13.2
2015	7	14	11	36	52	31	0	0	0	0	0	0	0	74.08	0	0	13.4
2015	7	14	11	46	52	31	0	0	0	0	0	0	0	74.03	0	0	13.4
2015	7	14	11	56	52	31	0	0	0	0	0	0	0	72.91	0	0	13.4
2015	7	14	12	6	52	31	0	0	0	0	0	0	0	72.81	0	0	13.4
2015	7	14	12	16	52	31	0	0	0	0	0	0	0	72.9	0	0	13.4
2015	7	14	12	26	52	31	0	0	0	0	0	0	0	73.09	0	0	13.4
2015	7	14	12	36	52	31	0	0	0	0	0	0	0	73.29	0	0	13.4
2015	7	14	12	46	52	30	0	0	0	0	0	0	0	73.54	0	0	13.4
2015	7	14	12	56	52	30	0	0	0	0	0	0	0	73.8	0	0	13.4
2015	7	14	13	6	52	30	0	0	0	0	0	0	0	74.1	0	0	13.4
2015	7	14	13	16	52	31	0	0	0	0	0	0	0	75.33	0	0	13.4
2015	7	14	13	26	52	31	0	0	0	0	0	0	0	76.15	0	0	13.4
2015	7	14	13	36	52	31	0	0	0	0	0	0	0	76.57	0	0	13.4
2015	7	14	13	46	52	30	0	0	0	0	0	0	0	76.93	0	0	13.4
2015	7	14	13	56	52	30	0	0	0	0	0	0	0	77.16	0	0	13.4
2015	7	14	14	6	52	30	0	0	0	0	0	0	0	77.43	0	0	13.2
2015	7	14	14	16	52	30	0	0	0	0	0	0	0	77.65	0	0	13.2
2015	7	14	14	26	52	31	0	0	0	0	0	0	0	77.85	0	0	13.2
2015	7	14	14	36	52	30	0	0	0	0	0	0	0	77.99	0	0	13.2
2015	7	14	14	46	52	29	0	0	0	0	0	0	0	78.17	0	0	13.2
2015	7	14	14	56	52	31	0	0	0	0	0	0	0	78.37	0	0	13.2
2015	7	14	15	6	52	31	0	0	0	0	0	0	0	78.49	0	0	13.2
2015	7	14	15	16	52	30	0	0	0	0	0	0	0	78.62	0	0	13.2
2015	7	14	15	26	52	29	0	0	0	0	0	0	0	78.42	0	0	12.8
2015	7	14	15	36	52	30	0	0	0	0	0	0	0	78.71	0	0	13.2
2015	7	14	15	46	52	30	0	0	0	0	0	0	0	78.89	0	0	13.2
2015	7	14	15	56	52	30	0	0	0	0	0	0	0	78.94	0	0	13.2
2015	7	14	16	6	52	30	0	0	0	0	0	0	0	79.07	0	0	13
2015	7	14	16	16	52	30	0	0	0	0	0	0	0	79.07	0	0	12.8
2015	7	14	16	26	52	30	0	0	0	0	0	0	0	79.14	0	0	12.8
2015	7	14	16	36	52	30	0	0	0	0	0	0	0	79.2	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	14	16	46	52	30	0	0	0	0	0	0	0	79.25	0	0	12.6
2015	7	14	16	56	52	30	0	0	0	0	0	0	0	79.25	0	0	12.4
2015	7	14	17	6	52	29	0	0	0	0	0	0	0	79.25	0	0	12.4
2015	7	14	17	16	52	30	0	0	0	0	0	0	0	79.27	0	0	12.4
2015	7	14	17	26	52	30	0	0	0	0	0	0	0	79.21	0	0	12.4
2015	7	14	17	36	52	30	0	0	0	0	0	0	0	78.98	0	0	12.2
2015	7	14	17	46	52	30	0	0	0	0	0	0	0	78.75	0	0	12.2
2015	7	14	17	56	52	30	0	0	0	0	0	0	0	78.67	0	0	12.2
2015	7	14	18	6	52	30	0	0	0	0	0	0	0	78.64	0	0	12.2
2015	7	14	18	16	52	30	0	0	0	0	0	0	0	78.62	0	0	12.2
2015	7	14	18	26	52	30	0	0	0	0	0	0	0	78.6	0	0	12.2
2015	7	14	18	36	52	30	0	0	0	0	0	0	0	78.58	0	0	12.2
2015	7	14	18	46	52	30	0	0	0	0	0	0	0	78.57	0	0	12.2
2015	7	14	18	56	52	30	0	0	0	0	0	0	0	78.55	0	0	12.2
2015	7	14	19	6	52	30	0	0	0	0	0	0	0	78.53	0	0	12.2
2015	7	14	19	16	52	30	0	0	0	0	0	0	0	78.48	0	0	12.2
2015	7	14	19	26	52	30	0	0	0	0	0	0	0	78.46	0	0	12.2
2015	7	14	19	36	52	30	0	0	0	0	0	0	0	78.42	0	0	12.2
2015	7	14	19	46	52	30	0	0	0	0	0	0	0	78.39	0	0	12.2
2015	7	14	19	56	52	30	0	0	0	0	0	0	0	78.35	0	0	12.2
2015	7	14	20	6	52	30	0	0	0	0	0	0	0	78.3	0	0	12.2
2015	7	14	20	16	52	30	0	0	0	0	0	0	0	78.26	0	0	12.2
2015	7	14	20	26	52	30	0	0	0	0	0	0	0	78.21	0	0	12.2
2015	7	14	20	36	52	29	0	0	0	0	0	0	0	78.17	0	0	12.2
2015	7	14	20	46	52	30	0	0	0	0	0	0	0	78.12	0	0	12.2
2015	7	14	20	56	52	30	0	0	0	0	0	0	0	78.06	0	0	12.2
2015	7	14	21	6	52	30	0	0	0	0	0	0	0	78.01	0	0	12.2
2015	7	14	21	16	52	30	0	0	0	0	0	0	0	77.94	0	0	12.2
2015	7	14	21	26	52	30	0	0	0	0	0	0	0	77.88	0	0	12.2
2015	7	14	21	36	52	30	0	0	0	0	0	0	0	77.83	0	0	12
2015	7	14	21	46	52	30	0	0	0	0	0	0	0	77.77	0	0	12
2015	7	14	21	56	52	30	0	0	0	0	0	0	0	77.68	0	0	12
2015	7	14	22	6	52	30	0	0	0	0	0	0	0	77.59	0	0	12
2015	7	14	22	16	52	31	0	0	0	0	0	0	0	77.5	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	14	22	26	52	31	0	0	0	0	0	0	0	77.41	0	0	12
2015	7	14	22	36	52	30	0	0	0	0	0	0	0	77.29	0	0	12
2015	7	14	22	46	52	30	0	0	0	0	0	0	0	77.16	0	0	12
2015	7	14	22	56	52	30	0	0	0	0	0	0	0	77.04	0	0	12
2015	7	14	23	6	52	29	0	0	0	0	0	0	0	76.91	0	0	12
2015	7	14	23	16	52	30	0	0	0	0	0	0	0	76.77	0	0	12
2015	7	14	23	26	52	30	0	0	0	0	0	0	0	76.6	0	0	12
2015	7	14	23	36	52	31	0	0	0	0	0	0	0	76.46	0	0	12
2015	7	14	23	46	52	30	0	0	0	0	0	0	0	76.3	0	0	12
2015	7	14	23	56	52	30	0	0	0	0	0	0	0	76.14	0	0	12
2015	7	15	0	6	52	30	0	0	0	0	0	0	0	75.96	0	0	12
2015	7	15	0	16	52	31	0	0	0	0	0	0	0	75.79	0	0	12
2015	7	15	0	26	52	31	0	0	0	0	0	0	0	75.63	0	0	12
2015	7	15	0	36	52	30	0	0	0	0	0	0	0	75.45	0	0	12
2015	7	15	0	46	52	30	0	0	0	0	0	0	0	75.27	0	0	12
2015	7	15	0	56	52	30	0	0	0	0	0	0	0	75.09	0	0	12
2015	7	15	1	6	52	30	0	0	0	0	0	0	0	74.91	0	0	12
2015	7	15	1	16	52	30	0	0	0	0	0	0	0	74.73	0	0	12
2015	7	15	1	26	52	31	0	0	0	0	0	0	0	74.55	0	0	12
2015	7	15	1	36	52	31	0	0	0	0	0	0	0	74.37	0	0	12
2015	7	15	1	46	52	31	0	0	0	0	0	0	0	74.19	0	0	12
2015	7	15	1	56	52	30	0	0	0	0	0	0	0	73.99	0	0	12
2015	7	15	2	6	52	30	0	0	0	0	0	0	0	73.83	0	0	12
2015	7	15	2	16	52	30	0	0	0	0	0	0	0	73.63	0	0	12
2015	7	15	2	26	52	30	0	0	0	0	0	0	0	73.45	0	0	12
2015	7	15	2	36	52	30	0	0	0	0	0	0	0	73.27	0	0	12
2015	7	15	2	46	52	30	0	0	0	0	0	0	0	73.08	0	0	12
2015	7	15	2	56	52	30	0	0	0	0	0	0	0	72.9	0	0	12
2015	7	15	3	6	52	31	0	0	0	0	0	0	0	72.72	0	0	12
2015	7	15	3	16	52	30	0	0	0	0	0	0	0	72.55	0	0	12
2015	7	15	3	26	52	31	0	0	0	0	0	0	0	72.36	0	0	12
2015	7	15	3	36	52	31	0	0	0	0	0	0	0	72.19	0	0	12
2015	7	15	3	46	52	31	0	0	0	0	0	0	0	72.03	0	0	12
2015	7	15	3	56	52	31	0	0	0	0	0	0	0	71.85	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	15	4	6	52	31	0	0	0	0	0	0	0	71.71	0	0	12
2015	7	15	4	16	52	31	0	0	0	0	0	0	0	71.56	0	0	12
2015	7	15	4	26	52	31	0	0	0	0	0	0	0	71.4	0	0	12
2015	7	15	4	36	52	31	0	0	0	0	0	0	0	71.26	0	0	12
2015	7	15	4	46	52	30	0	0	0	0	0	0	0	71.11	0	0	12
2015	7	15	4	56	52	31	0	0	0	0	0	0	0	70.93	0	0	12
2015	7	15	5	6	52	30	0	0	0	0	0	0	0	70.79	0	0	12
2015	7	15	5	16	52	30	0	0	0	0	0	0	0	70.65	0	0	12
2015	7	15	5	26	52	30	0	0	0	0	0	0	0	70.48	0	0	12
2015	7	15	5	36	52	31	0	0	0	0	0	0	0	70.34	0	0	12
2015	7	15	5	46	52	31	0	0	0	0	0	0	0	70.18	0	0	12
2015	7	15	5	56	52	31	0	0	0	0	0	0	0	70.05	0	0	12
2015	7	15	6	6	52	31	0	0	0	0	0	0	0	69.91	0	0	12
2015	7	15	6	16	52	31	0	0	0	0	0	0	0	69.8	0	0	12
2015	7	15	6	26	52	31	0	0	0	0	0	0	0	69.67	0	0	12
2015	7	15	6	36	52	31	0	0	0	0	0	0	0	69.55	0	0	12
2015	7	15	6	46	52	31	0	0	0	0	0	0	0	69.48	0	0	12
2015	7	15	6	56	52	31	0	0	0	0	0	0	0	69.64	0	0	12.2
2015	7	15	7	6	52	30	0	0	0	0	0	0	0	69.73	0	0	12.2
2015	7	15	7	16	52	31	0	0	0	0	0	0	0	69.82	0	0	12.4
2015	7	15	7	26	52	31	0	0	0	0	0	0	0	69.91	0	0	12.6
2015	7	15	7	36	52	31	0	0	0	0	0	0	0	69.96	0	0	12.6
2015	7	15	7	46	52	30	0	0	0	0	0	0	0	70.05	0	0	12.8
2015	7	15	7	56	52	32	0	0	0	0	0	0	0	70.07	0	0	13
2015	7	15	8	6	52	31	0	0	0	0	0	0	0	70.12	0	0	13
2015	7	15	8	16	52	30	0	0	0	0	0	0	0	70.2	0	0	13
2015	7	15	8	26	52	32	0	0	0	0	0	0	0	70.39	0	0	13.2
2015	7	15	8	36	52	31	0	0	0	0	0	0	0	70.48	0	0	13.2
2015	7	15	8	46	52	32	0	0	0	0	0	0	0	69.48	0	0	13.2
2015	7	15	8	56	52	31	0	0	0	0	0	0	0	70.21	0	0	13.2
2015	7	15	9	6	52	31	0	0	0	0	0	0	0	70.36	0	0	13.2
2015	7	15	9	16	52	31	0	0	0	0	0	0	0	70.47	0	0	13.4
2015	7	15	9	26	52	31	0	0	0	0	0	0	0	70.65	0	0	13.4
2015	7	15	9	36	52	31	0	0	0	0	0	0	0	70.79	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	15	9	46	52	31	0	0	0	0	0	0	0	70.9	0	0	13.4
2015	7	15	9	56	52	30	0	0	0	0	0	0	0	71.02	0	0	13.2
2015	7	15	10	6	52	31	0	0	0	0	0	0	0	71.08	0	0	13.2
2015	7	15	10	16	52	31	0	0	0	0	0	0	0	71.2	0	0	13.2
2015	7	15	10	26	52	31	0	0	0	0	0	0	0	71.28	0	0	13.2
2015	7	15	10	36	52	31	0	0	0	0	0	0	0	71.44	0	0	13.2
2015	7	15	10	46	52	32	0	0	0	0	0	0	0	71.65	0	0	13.2
2015	7	15	10	56	52	31	0	0	0	0	0	0	0	71.8	0	0	13.2
2015	7	15	11	6	52	31	0	0	0	0	0	0	0	71.98	0	0	13.2
2015	7	15	11	16	52	31	0	0	0	0	0	0	0	72.27	0	0	13.2
2015	7	15	11	26	52	31	0	0	0	0	0	0	0	72.43	0	0	13.2
2015	7	15	11	36	52	31	0	0	0	0	0	0	0	72.68	0	0	13.2
2015	7	15	11	46	52	30	0	0	0	0	0	0	0	72.46	0	0	13.2
2015	7	15	11	56	52	30	0	0	0	0	0	0	0	71.65	0	0	13.2
2015	7	15	12	6	52	31	0	0	0	0	0	0	0	71.69	0	0	13.2
2015	7	15	12	16	52	31	0	0	0	0	0	0	0	71.89	0	0	13.2
2015	7	15	12	26	52	31	0	0	0	0	0	0	0	72.12	0	0	13.2
2015	7	15	12	36	52	31	0	0	0	0	0	0	0	72.41	0	0	13.2
2015	7	15	12	46	52	31	0	0	0	0	0	0	0	72.7	0	0	13.2
2015	7	15	12	56	52	31	0	0	0	0	0	0	0	73.02	0	0	13.2
2015	7	15	13	6	52	31	0	0	0	0	0	0	0	73.36	0	0	13.2
2015	7	15	13	16	52	30	0	0	0	0	0	0	0	74.68	0	0	13.2
2015	7	15	13	26	52	30	0	0	0	0	0	0	0	75.4	0	0	13.2
2015	7	15	13	36	52	30	0	0	0	0	0	0	0	75.83	0	0	13.2
2015	7	15	13	46	52	32	0	0	0	0	0	0	0	76.21	0	0	13.2
2015	7	15	13	56	52	30	0	0	0	0	0	0	0	76.42	0	0	13.2
2015	7	15	14	6	52	30	0	0	0	0	0	0	0	76.75	0	0	13.2
2015	7	15	14	16	52	31	0	0	0	0	0	0	0	77	0	0	13.2
2015	7	15	14	26	52	30	0	0	0	0	0	0	0	77.34	0	0	13.2
2015	7	15	14	36	52	30	0	0	0	0	0	0	0	77.61	0	0	13.2
2015	7	15	14	46	52	30	0	0	0	0	0	0	0	77.86	0	0	13.2
2015	7	15	14	56	52	31	0	0	0	0	0	0	0	78.1	0	0	13.2
2015	7	15	15	6	52	30	0	0	0	0	0	0	0	78.31	0	0	13.2
2015	7	15	15	16	52	30	0	0	0	0	0	0	0	78.51	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	15	15	26	52	30	0	0	0	0	0	0	0	78.75	0	0	13.2
2015	7	15	15	36	52	30	0	0	0	0	0	0	0	78.94	0	0	13.2
2015	7	15	15	46	52	30	0	0	0	0	0	0	0	79.12	0	0	13.2
2015	7	15	15	56	52	30	0	0	0	0	0	0	0	79.25	0	0	13
2015	7	15	16	6	52	30	0	0	0	0	0	0	0	79.36	0	0	13
2015	7	15	16	16	52	30	0	0	0	0	0	0	0	79.52	0	0	12.8
2015	7	15	16	26	52	30	0	0	0	0	0	0	0	79.61	0	0	12.8
2015	7	15	16	36	52	30	0	0	0	0	0	0	0	79.7	0	0	12.6
2015	7	15	16	46	52	30	0	0	0	0	0	0	0	79.79	0	0	12.6
2015	7	15	16	56	52	30	0	0	0	0	0	0	0	79.84	0	0	12.4
2015	7	15	17	6	52	29	0	0	0	0	0	0	0	79.88	0	0	12.4
2015	7	15	17	16	52	29	0	0	0	0	0	0	0	79.93	0	0	12.4
2015	7	15	17	26	52	30	0	0	0	0	0	0	0	79.93	0	0	12.2
2015	7	15	17	36	52	30	0	0	0	0	0	0	0	79.81	0	0	12.2
2015	7	15	17	46	52	30	0	0	0	0	0	0	0	79.68	0	0	12.2
2015	7	15	17	56	52	30	0	0	0	0	0	0	0	79.65	0	0	12.2
2015	7	15	18	6	52	30	0	0	0	0	0	0	0	79.63	0	0	12.2
2015	7	15	18	16	52	30	0	0	0	0	0	0	0	79.61	0	0	12.2
2015	7	15	18	26	52	30	0	0	0	0	0	0	0	79.59	0	0	12.2
2015	7	15	18	36	52	30	0	0	0	0	0	0	0	79.57	0	0	12.2
2015	7	15	18	46	52	30	0	0	0	0	0	0	0	79.54	0	0	12.2
2015	7	15	18	56	52	29	0	0	0	0	0	0	0	79.54	0	0	12.2
2015	7	15	19	6	52	30	0	0	0	0	0	0	0	79.48	0	0	12.2
2015	7	15	19	16	52	30	0	0	0	0	0	0	0	79.45	0	0	12.2
2015	7	15	19	26	52	30	0	0	0	0	0	0	0	79.38	0	0	12.2
2015	7	15	19	36	52	30	0	0	0	0	0	0	0	79.32	0	0	12.2
2015	7	15	19	46	52	29	0	0	0	0	0	0	0	79.23	0	0	12.2
2015	7	15	19	56	52	30	0	0	0	0	0	0	0	79.14	0	0	12.2
2015	7	15	20	6	52	30	0	0	0	0	0	0	0	79.05	0	0	12.2
2015	7	15	20	16	52	31	0	0	0	0	0	0	0	78.94	0	0	12.2
2015	7	15	20	26	52	30	0	0	0	0	0	0	0	78.84	0	0	12.2
2015	7	15	20	36	52	30	0	0	0	0	0	0	0	78.71	0	0	12.2
2015	7	15	20	46	52	30	0	0	0	0	0	0	0	78.58	0	0	12.2
2015	7	15	20	56	52	30	0	0	0	0	0	0	0	78.46	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	15	21	6	52	30	0	0	0	0	0	0	0	78.31	0	0	12.2
2015	7	15	21	16	52	31	0	0	0	0	0	0	0	78.15	0	0	12
2015	7	15	21	26	52	30	0	0	0	0	0	0	0	77.99	0	0	12
2015	7	15	21	36	52	31	0	0	0	0	0	0	0	77.81	0	0	12
2015	7	15	21	46	52	30	0	0	0	0	0	0	0	77.63	0	0	12
2015	7	15	21	56	52	30	0	0	0	0	0	0	0	77.45	0	0	12
2015	7	15	22	6	52	30	0	0	0	0	0	0	0	77.25	0	0	12
2015	7	15	22	16	52	30	0	0	0	0	0	0	0	77.05	0	0	12
2015	7	15	22	26	52	29	0	0	0	0	0	0	0	76.89	0	0	12
2015	7	15	22	36	52	30	0	0	0	0	0	0	0	76.71	0	0	12
2015	7	15	22	46	52	30	0	0	0	0	0	0	0	76.51	0	0	12
2015	7	15	22	56	52	30	0	0	0	0	0	0	0	76.3	0	0	12
2015	7	15	23	6	52	30	0	0	0	0	0	0	0	76.1	0	0	12
2015	7	15	23	16	52	31	0	0	0	0	0	0	0	75.9	0	0	12
2015	7	15	23	26	52	29	0	0	0	0	0	0	0	75.7	0	0	12
2015	7	15	23	36	52	31	0	0	0	0	0	0	0	75.51	0	0	12
2015	7	15	23	46	52	31	0	0	0	0	0	0	0	75.29	0	0	12
2015	7	15	23	56	52	30	0	0	0	0	0	0	0	75.11	0	0	12
2015	7	16	0	6	52	30	0	0	0	0	0	0	0	74.93	0	0	12
2015	7	16	0	16	52	31	0	0	0	0	0	0	0	74.75	0	0	12
2015	7	16	0	26	52	30	0	0	0	0	0	0	0	74.57	0	0	12
2015	7	16	0	36	52	30	0	0	0	0	0	0	0	74.41	0	0	12
2015	7	16	0	46	52	31	0	0	0	0	0	0	0	74.25	0	0	12
2015	7	16	0	56	52	30	0	0	0	0	0	0	0	74.1	0	0	12
2015	7	16	1	6	52	30	0	0	0	0	0	0	0	73.98	0	0	12
2015	7	16	1	16	52	30	0	0	0	0	0	0	0	73.83	0	0	12
2015	7	16	1	26	52	30	0	0	0	0	0	0	0	73.71	0	0	12
2015	7	16	1	36	52	30	0	0	0	0	0	0	0	73.6	0	0	12
2015	7	16	1	46	52	30	0	0	0	0	0	0	0	73.51	0	0	12
2015	7	16	1	56	52	31	0	0	0	0	0	0	0	73.4	0	0	12
2015	7	16	2	6	52	30	0	0	0	0	0	0	0	73.31	0	0	12
2015	7	16	2	16	52	30	0	0	0	0	0	0	0	73.22	0	0	12
2015	7	16	2	26	52	30	0	0	0	0	0	0	0	73.11	0	0	12
2015	7	16	2	36	52	30	0	0	0	0	0	0	0	73	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	16	2	46	52	30	0	0	0	0	0	0	0	72.9	0	0	12
2015	7	16	2	56	52	30	0	0	0	0	0	0	0	72.81	0	0	12
2015	7	16	3	6	52	31	0	0	0	0	0	0	0	72.68	0	0	12
2015	7	16	3	16	52	30	0	0	0	0	0	0	0	72.55	0	0	12
2015	7	16	3	26	52	30	0	0	0	0	0	0	0	72.46	0	0	12
2015	7	16	3	36	52	31	0	0	0	0	0	0	0	72.37	0	0	12
2015	7	16	3	46	52	31	0	0	0	0	0	0	0	72.28	0	0	12
2015	7	16	3	56	52	30	0	0	0	0	0	0	0	72.19	0	0	12
2015	7	16	4	6	52	31	0	0	0	0	0	0	0	72.09	0	0	12
2015	7	16	4	16	52	31	0	0	0	0	0	0	0	72.01	0	0	12
2015	7	16	4	26	52	31	0	0	0	0	0	0	0	71.92	0	0	12
2015	7	16	4	36	52	31	0	0	0	0	0	0	0	71.83	0	0	12
2015	7	16	4	46	52	31	0	0	0	0	0	0	0	71.74	0	0	12
2015	7	16	4	56	52	31	0	0	0	0	0	0	0	71.65	0	0	12
2015	7	16	5	6	52	31	0	0	0	0	0	0	0	71.55	0	0	12
2015	7	16	5	16	52	30	0	0	0	0	0	0	0	71.44	0	0	12
2015	7	16	5	26	52	31	0	0	0	0	0	0	0	71.33	0	0	12
2015	7	16	5	36	52	31	0	0	0	0	0	0	0	71.24	0	0	12
2015	7	16	5	46	52	31	0	0	0	0	0	0	0	71.15	0	0	12
2015	7	16	5	56	52	31	0	0	0	0	0	0	0	71.04	0	0	12
2015	7	16	6	6	52	30	0	0	0	0	0	0	0	70.95	0	0	12
2015	7	16	6	16	52	30	0	0	0	0	0	0	0	70.86	0	0	12
2015	7	16	6	26	52	31	0	0	0	0	0	0	0	70.79	0	0	12
2015	7	16	6	36	52	31	0	0	0	0	0	0	0	70.7	0	0	12
2015	7	16	6	46	52	31	0	0	0	0	0	0	0	70.61	0	0	12
2015	7	16	6	56	52	31	0	0	0	0	0	0	0	70.74	0	0	12.2
2015	7	16	7	6	52	31	0	0	0	0	0	0	0	70.74	0	0	12.2
2015	7	16	7	16	52	31	0	0	0	0	0	0	0	70.83	0	0	12.4
2015	7	16	7	26	52	31	0	0	0	0	0	0	0	70.92	0	0	12.6
2015	7	16	7	36	52	31	0	0	0	0	0	0	0	70.95	0	0	12.6
2015	7	16	7	46	52	30	0	0	0	0	0	0	0	71.01	0	0	12.8
2015	7	16	7	56	52	30	0	0	0	0	0	0	0	71.1	0	0	13
2015	7	16	8	6	52	31	0	0	0	0	0	0	0	71.17	0	0	13
2015	7	16	8	16	52	30	0	0	0	0	0	0	0	71.26	0	0	13

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	16	8	26	52	32	0	0	0	0	0	0	0	71.35	0	0	13
2015	7	16	8	36	52	31	0	0	0	0	0	0	0	71.46	0	0	13
2015	7	16	8	46	52	31	0	0	0	0	0	0	0	71.56	0	0	13.2
2015	7	16	8	56	52	31	0	0	0	0	0	0	0	71.69	0	0	13.2
2015	7	16	9	6	52	31	0	0	0	0	0	0	0	71.8	0	0	13.2
2015	7	16	9	16	52	31	0	0	0	0	0	0	0	71.91	0	0	13.2
2015	7	16	9	26	52	31	0	0	0	0	0	0	0	72.05	0	0	13.2
2015	7	16	9	36	52	31	0	0	0	0	0	0	0	72.21	0	0	13.2
2015	7	16	9	46	52	30	0	0	0	0	0	0	0	72.28	0	0	13.2
2015	7	16	9	56	52	31	0	0	0	0	0	0	0	72.45	0	0	13.2
2015	7	16	10	6	52	30	0	0	0	0	0	0	0	72.25	0	0	13.2
2015	7	16	10	16	52	31	0	0	0	0	0	0	0	72.28	0	0	13.2
2015	7	16	10	26	52	31	0	0	0	0	0	0	0	72.39	0	0	13.2
2015	7	16	10	36	52	31	0	0	0	0	0	0	0	72.55	0	0	13.2
2015	7	16	10	46	52	31	0	0	0	0	0	0	0	72.7	0	0	13.4
2015	7	16	10	56	52	31	0	0	0	0	0	0	0	72.86	0	0	13.4
2015	7	16	11	6	52	30	0	0	0	0	0	0	0	73.02	0	0	13.4
2015	7	16	11	16	52	31	0	0	0	0	0	0	0	73.22	0	0	13.4
2015	7	16	11	26	52	30	0	0	0	0	0	0	0	73.31	0	0	13.4
2015	7	16	11	36	52	31	0	0	0	0	0	0	0	73.56	0	0	13.4
2015	7	16	11	46	52	30	0	0	0	0	0	0	0	73.27	0	0	13.4
2015	7	16	11	56	52	31	0	0	0	0	0	0	0	72.86	0	0	13.4
2015	7	16	12	6	52	31	0	0	0	0	0	0	0	72.95	0	0	13.2
2015	7	16	12	16	52	30	0	0	0	0	0	0	0	73.13	0	0	13.2
2015	7	16	12	26	52	31	0	0	0	0	0	0	0	73.36	0	0	13.2
2015	7	16	12	36	52	31	0	0	0	0	0	0	0	73.6	0	0	13.2
2015	7	16	12	46	52	31	0	0	0	0	0	0	0	73.85	0	0	13.2
2015	7	16	12	56	52	31	0	0	0	0	0	0	0	74.14	0	0	13.2
2015	7	16	13	6	52	30	0	0	0	0	0	0	0	74.46	0	0	13.2
2015	7	16	13	16	52	31	0	0	0	0	0	0	0	75.47	0	0	13.2
2015	7	16	13	26	52	31	0	0	0	0	0	0	0	75.96	0	0	13.2
2015	7	16	13	36	52	31	0	0	0	0	0	0	0	76.28	0	0	13.2
2015	7	16	13	46	52	31	0	0	0	0	0	0	0	76.55	0	0	13.2
2015	7	16	13	56	52	30	0	0	0	0	0	0	0	76.84	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	16	14	6	52	31	0	0	0	0	0	0	0	77.09	0	0	13.2
2015	7	16	14	16	52	30	0	0	0	0	0	0	0	77.31	0	0	13.2
2015	7	16	14	26	52	30	0	0	0	0	0	0	0	77.52	0	0	13.2
2015	7	16	14	36	52	30	0	0	0	0	0	0	0	77.74	0	0	13.2
2015	7	16	14	46	52	31	0	0	0	0	0	0	0	77.94	0	0	13.2
2015	7	16	14	56	52	30	0	0	0	0	0	0	0	78.12	0	0	13.2
2015	7	16	15	6	52	30	0	0	0	0	0	0	0	78.3	0	0	13.2
2015	7	16	15	16	52	30	0	0	0	0	0	0	0	78.42	0	0	13.2
2015	7	16	15	26	52	30	0	0	0	0	0	0	0	78.53	0	0	13.2
2015	7	16	15	36	52	30	0	0	0	0	0	0	0	78.67	0	0	13.2
2015	7	16	15	46	52	30	0	0	0	0	0	0	0	78.82	0	0	13.2
2015	7	16	15	56	52	29	0	0	0	0	0	0	0	78.84	0	0	13
2015	7	16	16	6	52	30	0	0	0	0	0	0	0	78.93	0	0	13
2015	7	16	16	16	52	30	0	0	0	0	0	0	0	78.87	0	0	13
2015	7	16	16	26	52	30	0	0	0	0	0	0	0	79.03	0	0	12.8
2015	7	16	16	36	52	29	0	0	0	0	0	0	0	79.09	0	0	12.8
2015	7	16	16	46	52	30	0	0	0	0	0	0	0	79.18	0	0	12.8
2015	7	16	16	56	52	30	0	0	0	0	0	0	0	79.21	0	0	12.6
2015	7	16	17	6	52	30	0	0	0	0	0	0	0	79.25	0	0	12.6
2015	7	16	17	16	52	30	0	0	0	0	0	0	0	79.23	0	0	12.4
2015	7	16	17	26	52	29	0	0	0	0	0	0	0	79.25	0	0	12.4
2015	7	16	17	36	52	30	0	0	0	0	0	0	0	79.11	0	0	12.2
2015	7	16	17	46	52	30	0	0	0	0	0	0	0	79	0	0	12.2
2015	7	16	17	56	52	30	0	0	0	0	0	0	0	78.94	0	0	12.2
2015	7	16	18	6	52	30	0	0	0	0	0	0	0	78.89	0	0	12.2
2015	7	16	18	16	52	30	0	0	0	0	0	0	0	78.85	0	0	12.2
2015	7	16	18	26	52	30	0	0	0	0	0	0	0	78.78	0	0	12.2
2015	7	16	18	36	52	30	0	0	0	0	0	0	0	78.71	0	0	12.2
2015	7	16	18	46	52	30	0	0	0	0	0	0	0	78.62	0	0	12.2
2015	7	16	18	56	52	30	0	0	0	0	0	0	0	78.57	0	0	12.2
2015	7	16	19	6	52	30	0	0	0	0	0	0	0	78.49	0	0	12.2
2015	7	16	19	16	52	30	0	0	0	0	0	0	0	78.44	0	0	12.2
2015	7	16	19	26	52	30	0	0	0	0	0	0	0	78.39	0	0	12.2
2015	7	16	19	36	52	30	0	0	0	0	0	0	0	78.33	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	16	19	46	52	30	0	0	0	0	0	0	0	78.28	0	0	12.2
2015	7	16	19	56	52	30	0	0	0	0	0	0	0	78.21	0	0	12.2
2015	7	16	20	6	52	30	0	0	0	0	0	0	0	78.13	0	0	12.2
2015	7	16	20	16	52	30	0	0	0	0	0	0	0	78.04	0	0	12.2
2015	7	16	20	26	52	30	0	0	0	0	0	0	0	77.95	0	0	12.2
2015	7	16	20	36	52	30	0	0	0	0	0	0	0	77.83	0	0	12.2
2015	7	16	20	46	52	30	0	0	0	0	0	0	0	77.7	0	0	12.2
2015	7	16	20	56	52	30	0	0	0	0	0	0	0	77.56	0	0	12.2
2015	7	16	21	6	52	31	0	0	0	0	0	0	0	77.43	0	0	12
2015	7	16	21	16	52	30	0	0	0	0	0	0	0	77.25	0	0	12
2015	7	16	21	26	52	30	0	0	0	0	0	0	0	77.11	0	0	12
2015	7	16	21	36	52	30	0	0	0	0	0	0	0	76.95	0	0	12
2015	7	16	21	46	52	30	0	0	0	0	0	0	0	76.78	0	0	12
2015	7	16	21	56	52	30	0	0	0	0	0	0	0	76.62	0	0	12
2015	7	16	22	6	52	30	0	0	0	0	0	0	0	76.46	0	0	12
2015	7	16	22	16	52	30	0	0	0	0	0	0	0	76.26	0	0	12
2015	7	16	22	26	52	30	0	0	0	0	0	0	0	76.1	0	0	12
2015	7	16	22	36	52	30	0	0	0	0	0	0	0	75.9	0	0	12
2015	7	16	22	46	52	30	0	0	0	0	0	0	0	75.7	0	0	12
2015	7	16	22	56	52	30	0	0	0	0	0	0	0	75.51	0	0	12
2015	7	16	23	6	52	31	0	0	0	0	0	0	0	75.31	0	0	12
2015	7	16	23	16	52	30	0	0	0	0	0	0	0	75.11	0	0	12
2015	7	16	23	26	52	30	0	0	0	0	0	0	0	74.91	0	0	12
2015	7	16	23	36	52	31	0	0	0	0	0	0	0	74.73	0	0	12
2015	7	16	23	46	52	31	0	0	0	0	0	0	0	74.55	0	0	12
2015	7	16	23	56	52	30	0	0	0	0	0	0	0	74.39	0	0	12
2015	7	17	0	6	52	31	0	0	0	0	0	0	0	74.23	0	0	12
2015	7	17	0	16	52	31	0	0	0	0	0	0	0	74.07	0	0	12
2015	7	17	0	26	52	30	0	0	0	0	0	0	0	73.92	0	0	12
2015	7	17	0	36	52	30	0	0	0	0	0	0	0	73.76	0	0	12
2015	7	17	0	46	52	31	0	0	0	0	0	0	0	73.62	0	0	12
2015	7	17	0	56	52	31	0	0	0	0	0	0	0	73.47	0	0	12
2015	7	17	1	6	52	31	0	0	0	0	0	0	0	73.35	0	0	12
2015	7	17	1	16	52	31	0	0	0	0	0	0	0	73.22	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	17	1	26	52	31	0	0	0	0	0	0	0	73.08	0	0	12
2015	7	17	1	36	52	31	0	0	0	0	0	0	0	72.95	0	0	12
2015	7	17	1	46	52	31	0	0	0	0	0	0	0	72.81	0	0	12
2015	7	17	1	56	52	31	0	0	0	0	0	0	0	72.68	0	0	12
2015	7	17	2	6	52	30	0	0	0	0	0	0	0	72.55	0	0	12
2015	7	17	2	16	52	31	0	0	0	0	0	0	0	72.43	0	0	12
2015	7	17	2	26	52	31	0	0	0	0	0	0	0	72.32	0	0	12
2015	7	17	2	36	52	31	0	0	0	0	0	0	0	72.19	0	0	12
2015	7	17	2	46	52	30	0	0	0	0	0	0	0	72.05	0	0	12
2015	7	17	2	56	52	31	0	0	0	0	0	0	0	71.94	0	0	12
2015	7	17	3	6	52	31	0	0	0	0	0	0	0	71.83	0	0	12
2015	7	17	3	16	52	30	0	0	0	0	0	0	0	71.71	0	0	12
2015	7	17	3	26	52	31	0	0	0	0	0	0	0	71.6	0	0	12
2015	7	17	3	36	52	30	0	0	0	0	0	0	0	71.49	0	0	12
2015	7	17	3	46	52	31	0	0	0	0	0	0	0	71.37	0	0	12
2015	7	17	3	56	52	30	0	0	0	0	0	0	0	71.26	0	0	12
2015	7	17	4	6	52	30	0	0	0	0	0	0	0	71.13	0	0	12
2015	7	17	4	16	52	30	0	0	0	0	0	0	0	71.01	0	0	12
2015	7	17	4	26	52	31	0	0	0	0	0	0	0	70.9	0	0	12
2015	7	17	4	36	52	31	0	0	0	0	0	0	0	70.79	0	0	12
2015	7	17	4	46	52	31	0	0	0	0	0	0	0	70.68	0	0	12
2015	7	17	4	56	52	31	0	0	0	0	0	0	0	70.57	0	0	12
2015	7	17	5	6	52	31	0	0	0	0	0	0	0	70.47	0	0	12
2015	7	17	5	16	52	31	0	0	0	0	0	0	0	70.38	0	0	12
2015	7	17	5	26	52	30	0	0	0	0	0	0	0	70.27	0	0	12
2015	7	17	5	36	52	31	0	0	0	0	0	0	0	70.16	0	0	11.8
2015	7	17	5	46	52	31	0	0	0	0	0	0	0	70.07	0	0	11.8
2015	7	17	5	56	52	31	0	0	0	0	0	0	0	69.98	0	0	11.8
2015	7	17	6	6	52	31	0	0	0	0	0	0	0	69.89	0	0	12
2015	7	17	6	16	52	31	0	0	0	0	0	0	0	69.8	0	0	12
2015	7	17	6	26	52	31	0	0	0	0	0	0	0	69.71	0	0	12
2015	7	17	6	36	52	31	0	0	0	0	0	0	0	69.6	0	0	12
2015	7	17	6	46	52	32	0	0	0	0	0	0	0	69.53	0	0	12
2015	7	17	6	56	52	31	0	0	0	0	0	0	0	69.64	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	17	7	6	52	31	0	0	0	0	0	0	0	69.66	0	0	12.4
2015	7	17	7	16	52	30	0	0	0	0	0	0	0	69.71	0	0	12.4
2015	7	17	7	26	52	30	0	0	0	0	0	0	0	69.75	0	0	12.6
2015	7	17	7	36	52	31	0	0	0	0	0	0	0	69.87	0	0	12.8
2015	7	17	7	46	52	31	0	0	0	0	0	0	0	69.93	0	0	12.8
2015	7	17	7	56	52	31	0	0	0	0	0	0	0	69.98	0	0	13
2015	7	17	8	6	52	30	0	0	0	0	0	0	0	70.05	0	0	13
2015	7	17	8	16	52	31	0	0	0	0	0	0	0	70.11	0	0	13.2
2015	7	17	8	26	52	31	0	0	0	0	0	0	0	70.18	0	0	13.2
2015	7	17	8	36	52	30	0	0	0	0	0	0	0	70.34	0	0	13.2
2015	7	17	8	46	52	31	0	0	0	0	0	0	0	70.41	0	0	13.2
2015	7	17	8	56	52	31	0	0	0	0	0	0	0	70.52	0	0	13.2
2015	7	17	9	6	52	31	0	0	0	0	0	0	0	70.68	0	0	13.2
2015	7	17	9	16	52	30	0	0	0	0	0	0	0	70.83	0	0	13.2
2015	7	17	9	26	52	31	0	0	0	0	0	0	0	70.97	0	0	13.2
2015	7	17	9	36	52	31	0	0	0	0	0	0	0	71.08	0	0	13.2
2015	7	17	9	46	52	31	0	0	0	0	0	0	0	71.26	0	0	13.2
2015	7	17	9	56	52	31	0	0	0	0	0	0	0	71.42	0	0	13.2
2015	7	17	10	6	52	30	0	0	0	0	0	0	0	71.6	0	0	13.2
2015	7	17	10	16	52	30	0	0	0	0	0	0	0	71.78	0	0	13.2
2015	7	17	10	26	52	31	0	0	0	0	0	0	0	71.94	0	0	13.2
2015	7	17	10	36	52	30	0	0	0	0	0	0	0	72.16	0	0	13.2
2015	7	17	10	46	52	31	0	0	0	0	0	0	0	72.32	0	0	13.2
2015	7	17	10	56	52	31	0	0	0	0	0	0	0	72.46	0	0	13.2
2015	7	17	11	6	52	31	0	0	0	0	0	0	0	72.7	0	0	13.2
2015	7	17	11	16	52	31	0	0	0	0	0	0	0	72.84	0	0	13.2
2015	7	17	11	26	52	31	0	0	0	0	0	0	0	73.06	0	0	13.2
2015	7	17	11	36	52	31	0	0	0	0	0	0	0	73.24	0	0	13.2
2015	7	17	11	46	52	31	0	0	0	0	0	0	0	72.88	0	0	13.2
2015	7	17	11	56	52	31	0	0	0	0	0	0	0	72.36	0	0	13.2
2015	7	17	12	6	52	30	0	0	0	0	0	0	0	72.41	0	0	13.2
2015	7	17	12	16	52	31	0	0	0	0	0	0	0	72.57	0	0	13.2
2015	7	17	12	26	52	31	0	0	0	0	0	0	0	72.77	0	0	13.2
2015	7	17	12	36	52	31	0	0	0	0	0	0	0	72.99	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	17	12	46	52	30	0	0	0	0	0	0	0	73.22	0	0	13.2
2015	7	17	12	56	52	31	0	0	0	0	0	0	0	73.47	0	0	13.2
2015	7	17	13	6	52	31	0	0	0	0	0	0	0	73.8	0	0	13.2
2015	7	17	13	16	52	30	0	0	0	0	0	0	0	74.98	0	0	13.2
2015	7	17	13	26	52	31	0	0	0	0	0	0	0	75.47	0	0	13.2
2015	7	17	13	36	52	30	0	0	0	0	0	0	0	75.79	0	0	13.2
2015	7	17	13	46	52	30	0	0	0	0	0	0	0	76.06	0	0	13.2
2015	7	17	13	56	52	31	0	0	0	0	0	0	0	76.35	0	0	13.2
2015	7	17	14	6	52	31	0	0	0	0	0	0	0	76.55	0	0	13.2
2015	7	17	14	16	52	31	0	0	0	0	0	0	0	76.8	0	0	13.2
2015	7	17	14	26	52	30	0	0	0	0	0	0	0	77.04	0	0	13.2
2015	7	17	14	36	52	30	0	0	0	0	0	0	0	77.22	0	0	13.2
2015	7	17	14	46	52	30	0	0	0	0	0	0	0	77.41	0	0	13.2
2015	7	17	14	56	52	30	0	0	0	0	0	0	0	77.58	0	0	13.2
2015	7	17	15	6	52	29	0	0	0	0	0	0	0	77.74	0	0	13.2
2015	7	17	15	16	52	30	0	0	0	0	0	0	0	77.88	0	0	13.2
2015	7	17	15	26	52	30	0	0	0	0	0	0	0	78.03	0	0	13.2
2015	7	17	15	36	52	30	0	0	0	0	0	0	0	77.76	0	0	12.8
2015	7	17	15	46	52	30	0	0	0	0	0	0	0	78.06	0	0	13.2
2015	7	17	15	56	52	30	0	0	0	0	0	0	0	78.21	0	0	13
2015	7	17	16	6	52	30	0	0	0	0	0	0	0	78.31	0	0	13
2015	7	17	16	16	52	30	0	0	0	0	0	0	0	78.35	0	0	13
2015	7	17	16	26	52	30	0	0	0	0	0	0	0	78.4	0	0	12.8
2015	7	17	16	36	52	30	0	0	0	0	0	0	0	78.44	0	0	12.6
2015	7	17	16	46	52	30	0	0	0	0	0	0	0	78.49	0	0	12.6
2015	7	17	16	56	52	30	0	0	0	0	0	0	0	78.53	0	0	12.4
2015	7	17	17	6	52	29	0	0	0	0	0	0	0	78.55	0	0	12.4
2015	7	17	17	16	52	30	0	0	0	0	0	0	0	78.58	0	0	12.4
2015	7	17	17	26	52	29	0	0	0	0	0	0	0	78.6	0	0	12.2
2015	7	17	17	36	52	30	0	0	0	0	0	0	0	78.42	0	0	12.2
2015	7	17	17	46	52	30	0	0	0	0	0	0	0	78.33	0	0	12.2
2015	7	17	17	56	52	30	0	0	0	0	0	0	0	78.3	0	0	12.2
2015	7	17	18	6	52	30	0	0	0	0	0	0	0	78.3	0	0	12.2
2015	7	17	18	16	52	29	0	0	0	0	0	0	0	78.3	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	17	18	26	52	30	0	0	0	0	0	0	0	78.28	0	0	12.2
2015	7	17	18	36	52	30	0	0	0	0	0	0	0	78.26	0	0	12.2
2015	7	17	18	46	52	30	0	0	0	0	0	0	0	78.24	0	0	12.2
2015	7	17	18	56	52	30	0	0	0	0	0	0	0	78.21	0	0	12.2
2015	7	17	19	6	52	30	0	0	0	0	0	0	0	78.17	0	0	12.2
2015	7	17	19	16	52	31	0	0	0	0	0	0	0	78.13	0	0	12.2
2015	7	17	19	26	52	30	0	0	0	0	0	0	0	78.08	0	0	12.2
2015	7	17	19	36	52	30	0	0	0	0	0	0	0	78.03	0	0	12.2
2015	7	17	19	46	52	30	0	0	0	0	0	0	0	77.99	0	0	12.2
2015	7	17	19	56	52	30	0	0	0	0	0	0	0	77.94	0	0	12.2
2015	7	17	20	6	52	30	0	0	0	0	0	0	0	77.85	0	0	12.2
2015	7	17	20	16	52	30	0	0	0	0	0	0	0	77.81	0	0	12.2
2015	7	17	20	26	52	30	0	0	0	0	0	0	0	77.72	0	0	12.2
2015	7	17	20	36	52	30	0	0	0	0	0	0	0	77.65	0	0	12.2
2015	7	17	20	46	52	30	0	0	0	0	0	0	0	77.58	0	0	12.2
2015	7	17	20	56	52	31	0	0	0	0	0	0	0	77.47	0	0	12.2
2015	7	17	21	6	52	29	0	0	0	0	0	0	0	77.38	0	0	12.2
2015	7	17	21	16	52	30	0	0	0	0	0	0	0	77.25	0	0	12
2015	7	17	21	26	52	31	0	0	0	0	0	0	0	77.13	0	0	12
2015	7	17	21	36	52	30	0	0	0	0	0	0	0	77	0	0	12
2015	7	17	21	46	52	31	0	0	0	0	0	0	0	76.86	0	0	12
2015	7	17	21	56	52	30	0	0	0	0	0	0	0	76.71	0	0	12
2015	7	17	22	6	52	30	0	0	0	0	0	0	0	76.57	0	0	12
2015	7	17	22	16	52	31	0	0	0	0	0	0	0	76.41	0	0	12
2015	7	17	22	26	52	30	0	0	0	0	0	0	0	76.24	0	0	12
2015	7	17	22	36	52	30	0	0	0	0	0	0	0	76.08	0	0	12
2015	7	17	22	46	52	31	0	0	0	0	0	0	0	75.94	0	0	12
2015	7	17	22	56	52	31	0	0	0	0	0	0	0	75.76	0	0	12
2015	7	17	23	6	52	31	0	0	0	0	0	0	0	75.6	0	0	12
2015	7	17	23	16	52	30	0	0	0	0	0	0	0	75.43	0	0	12
2015	7	17	23	26	52	30	0	0	0	0	0	0	0	75.27	0	0	12
2015	7	17	23	36	52	30	0	0	0	0	0	0	0	75.11	0	0	12
2015	7	17	23	46	52	30	0	0	0	0	0	0	0	74.95	0	0	12
2015	7	17	23	56	52	30	0	0	0	0	0	0	0	74.79	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	18	0	6	52	31	0	0	0	0	0	0	0	74.62	0	0	12
2015	7	18	0	16	52	30	0	0	0	0	0	0	0	74.46	0	0	12
2015	7	18	0	26	52	30	0	0	0	0	0	0	0	74.3	0	0	12
2015	7	18	0	36	52	31	0	0	0	0	0	0	0	74.12	0	0	12
2015	7	18	0	46	52	29	0	0	0	0	0	0	0	73.98	0	0	12
2015	7	18	0	56	52	31	0	0	0	0	0	0	0	73.8	0	0	12
2015	7	18	1	6	52	30	0	0	0	0	0	0	0	73.65	0	0	12
2015	7	18	1	16	52	30	0	0	0	0	0	0	0	73.51	0	0	12
2015	7	18	1	26	52	31	0	0	0	0	0	0	0	73.36	0	0	12
2015	7	18	1	36	52	31	0	0	0	0	0	0	0	73.24	0	0	12
2015	7	18	1	46	52	31	0	0	0	0	0	0	0	73.08	0	0	12
2015	7	18	1	56	52	31	0	0	0	0	0	0	0	72.95	0	0	12
2015	7	18	2	6	52	31	0	0	0	0	0	0	0	72.81	0	0	12
2015	7	18	2	16	52	30	0	0	0	0	0	0	0	72.66	0	0	12
2015	7	18	2	26	52	30	0	0	0	0	0	0	0	72.52	0	0	12
2015	7	18	2	36	52	30	0	0	0	0	0	0	0	72.39	0	0	12
2015	7	18	2	46	52	30	0	0	0	0	0	0	0	72.25	0	0	12
2015	7	18	2	56	52	31	0	0	0	0	0	0	0	72.1	0	0	12
2015	7	18	3	6	52	30	0	0	0	0	0	0	0	71.96	0	0	12
2015	7	18	3	16	52	31	0	0	0	0	0	0	0	71.82	0	0	12
2015	7	18	3	26	52	30	0	0	0	0	0	0	0	71.71	0	0	12
2015	7	18	3	36	52	31	0	0	0	0	0	0	0	71.56	0	0	12
2015	7	18	3	46	52	31	0	0	0	0	0	0	0	71.42	0	0	12
2015	7	18	3	56	52	31	0	0	0	0	0	0	0	71.29	0	0	12
2015	7	18	4	6	52	32	0	0	0	0	0	0	0	71.15	0	0	12
2015	7	18	4	16	52	31	0	0	0	0	0	0	0	71.02	0	0	12
2015	7	18	4	26	52	31	0	0	0	0	0	0	0	70.9	0	0	12
2015	7	18	4	36	52	32	0	0	0	0	0	0	0	70.77	0	0	12
2015	7	18	4	46	52	31	0	0	0	0	0	0	0	70.65	0	0	12
2015	7	18	4	56	52	31	0	0	0	0	0	0	0	70.52	0	0	12
2015	7	18	5	6	52	31	0	0	0	0	0	0	0	70.39	0	0	12
2015	7	18	5	16	52	31	0	0	0	0	0	0	0	70.27	0	0	12
2015	7	18	5	26	52	30	0	0	0	0	0	0	0	70.16	0	0	12
2015	7	18	5	36	52	31	0	0	0	0	0	0	0	70.03	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	18	5	46	52	31	0	0	0	0	0	0	0	69.93	0	0	12
2015	7	18	5	56	52	31	0	0	0	0	0	0	0	69.82	0	0	12
2015	7	18	6	6	52	31	0	0	0	0	0	0	0	69.71	0	0	12
2015	7	18	6	16	52	31	0	0	0	0	0	0	0	69.6	0	0	12
2015	7	18	6	26	52	31	0	0	0	0	0	0	0	69.51	0	0	12
2015	7	18	6	36	52	31	0	0	0	0	0	0	0	69.42	0	0	12
2015	7	18	6	46	52	31	0	0	0	0	0	0	0	69.31	0	0	12
2015	7	18	6	56	52	31	0	0	0	0	0	0	0	69.42	0	0	12.2
2015	7	18	7	6	52	31	0	0	0	0	0	0	0	69.48	0	0	12.4
2015	7	18	7	16	52	31	0	0	0	0	0	0	0	69.48	0	0	12.4
2015	7	18	7	26	52	31	0	0	0	0	0	0	0	69.6	0	0	12.6
2015	7	18	7	36	52	31	0	0	0	0	0	0	0	69.69	0	0	12.8
2015	7	18	7	46	52	32	0	0	0	0	0	0	0	69.8	0	0	12.8
2015	7	18	7	56	52	31	0	0	0	0	0	0	0	69.91	0	0	13
2015	7	18	8	6	52	30	0	0	0	0	0	0	0	69.94	0	0	13
2015	7	18	8	16	52	31	0	0	0	0	0	0	0	70	0	0	13
2015	7	18	8	26	52	30	0	0	0	0	0	0	0	70.12	0	0	13.2
2015	7	18	8	36	52	31	0	0	0	0	0	0	0	70.25	0	0	13.2
2015	7	18	8	46	52	31	0	0	0	0	0	0	0	70.32	0	0	13.2
2015	7	18	8	56	52	31	0	0	0	0	0	0	0	70.5	0	0	13.2
2015	7	18	9	6	52	32	0	0	0	0	0	0	0	70.65	0	0	13.2
2015	7	18	9	16	52	31	0	0	0	0	0	0	0	70.83	0	0	13.2
2015	7	18	9	26	52	31	0	0	0	0	0	0	0	70.97	0	0	13.2
2015	7	18	9	36	52	31	0	0	0	0	0	0	0	71.15	0	0	13.2
2015	7	18	9	46	52	31	0	0	0	0	0	0	0	71.31	0	0	13.2
2015	7	18	9	56	52	31	0	0	0	0	0	0	0	71.4	0	0	13.2
2015	7	18	10	6	52	31	0	0	0	0	0	0	0	71.53	0	0	13.2
2015	7	18	10	16	52	31	0	0	0	0	0	0	0	71.65	0	0	13.2
2015	7	18	10	26	52	31	0	0	0	0	0	0	0	71.8	0	0	13.2
2015	7	18	10	36	52	32	0	0	0	0	0	0	0	71.96	0	0	13.2
2015	7	18	10	46	52	31	0	0	0	0	0	0	0	72.09	0	0	13.4
2015	7	18	10	56	52	31	0	0	0	0	0	0	0	72.25	0	0	13.4
2015	7	18	11	6	52	30	0	0	0	0	0	0	0	72.48	0	0	13.4
2015	7	18	11	16	52	31	0	0	0	0	0	0	0	72.73	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	18	11	26	52	31	0	0	0	0	0	0	0	72.88	0	0	13.2
2015	7	18	11	36	52	31	0	0	0	0	0	0	0	73.06	0	0	13.4
2015	7	18	11	46	52	30	0	0	0	0	0	0	0	72.57	0	0	13.2
2015	7	18	11	56	52	31	0	0	0	0	0	0	0	72.1	0	0	13.2
2015	7	18	12	6	52	31	0	0	0	0	0	0	0	72.16	0	0	13.2
2015	7	18	12	16	52	31	0	0	0	0	0	0	0	72.36	0	0	13.2
2015	7	18	12	26	52	30	0	0	0	0	0	0	0	72.64	0	0	13.2
2015	7	18	12	36	52	31	0	0	0	0	0	0	0	72.99	0	0	13.2
2015	7	18	12	46	52	31	0	0	0	0	0	0	0	73.26	0	0	13.2
2015	7	18	12	56	52	31	0	0	0	0	0	0	0	73.45	0	0	13.2
2015	7	18	13	6	52	31	0	0	0	0	0	0	0	73.81	0	0	13.2
2015	7	18	13	16	52	31	0	0	0	0	0	0	0	74.46	0	0	13.2
2015	7	18	13	26	52	31	0	0	0	0	0	0	0	74.5	0	0	12.8
2015	7	18	13	36	52	30	0	0	0	0	0	0	0	74.86	0	0	13
2015	7	18	13	46	52	30	0	0	0	0	0	0	0	75.65	0	0	13.2
2015	7	18	13	56	52	30	0	0	0	0	0	0	0	76.15	0	0	13.2
2015	7	18	14	6	52	30	0	0	0	0	0	0	0	75.97	0	0	13
2015	7	18	14	16	52	30	0	0	0	0	0	0	0	75.87	0	0	13.2
2015	7	18	14	26	52	31	0	0	0	0	0	0	0	75.96	0	0	13.2
2015	7	18	14	36	52	30	0	0	0	0	0	0	0	76.05	0	0	13.2
2015	7	18	14	46	52	31	0	0	0	0	0	0	0	75.92	0	0	13
2015	7	18	14	56	52	30	0	0	0	0	0	0	0	75.88	0	0	13
2015	7	18	15	6	52	31	0	0	0	0	0	0	0	76.03	0	0	13.2
2015	7	18	15	16	52	30	0	0	0	0	0	0	0	76.59	0	0	13.4
2015	7	18	15	26	52	31	0	0	0	0	0	0	0	76.59	0	0	13.4
2015	7	18	15	36	52	30	0	0	0	0	0	0	0	76.42	0	0	13.2
2015	7	18	15	46	52	30	0	0	0	0	0	0	0	76.69	0	0	13.4
2015	7	18	15	56	52	30	0	0	0	0	0	0	0	76.73	0	0	13.4
2015	7	18	16	6	52	30	0	0	0	0	0	0	0	76.55	0	0	13.2
2015	7	18	16	16	52	30	0	0	0	0	0	0	0	76.64	0	0	13.2
2015	7	18	16	26	52	31	0	0	0	0	0	0	0	76.64	0	0	12.8
2015	7	18	16	36	52	30	0	0	0	0	0	0	0	76.24	0	0	12.4
2015	7	18	16	46	52	30	0	0	0	0	0	0	0	76.24	0	0	12.4
2015	7	18	16	56	52	31	0	0	0	0	0	0	0	76.17	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	18	17	6	52	30	0	0	0	0	0	0	0	76.12	0	0	12.4
2015	7	18	17	16	52	30	0	0	0	0	0	0	0	75.99	0	0	12.4
2015	7	18	17	26	52	30	0	0	0	0	0	0	0	75.9	0	0	12.2
2015	7	18	17	36	52	30	0	0	0	0	0	0	0	75.76	0	0	12.2
2015	7	18	17	46	52	31	0	0	0	0	0	0	0	75.61	0	0	12.2
2015	7	18	17	56	52	30	0	0	0	0	0	0	0	75.52	0	0	12.2
2015	7	18	18	6	52	31	0	0	0	0	0	0	0	75.45	0	0	12.2
2015	7	18	18	16	52	30	0	0	0	0	0	0	0	75.38	0	0	12.2
2015	7	18	18	26	52	31	0	0	0	0	0	0	0	75.36	0	0	12.2
2015	7	18	18	36	52	30	0	0	0	0	0	0	0	75.31	0	0	12.2
2015	7	18	18	46	52	30	0	0	0	0	0	0	0	75.25	0	0	12.2
2015	7	18	18	56	52	31	0	0	0	0	0	0	0	75.18	0	0	12.2
2015	7	18	19	6	52	30	0	0	0	0	0	0	0	75.09	0	0	12.2
2015	7	18	19	16	52	31	0	0	0	0	0	0	0	75	0	0	12.2
2015	7	18	19	26	52	31	0	0	0	0	0	0	0	74.93	0	0	12.2
2015	7	18	19	36	52	30	0	0	0	0	0	0	0	74.86	0	0	12.2
2015	7	18	19	46	52	31	0	0	0	0	0	0	0	74.77	0	0	12
2015	7	18	19	56	52	31	0	0	0	0	0	0	0	74.66	0	0	12
2015	7	18	20	6	52	30	0	0	0	0	0	0	0	74.57	0	0	12
2015	7	18	20	16	52	30	0	0	0	0	0	0	0	74.44	0	0	12
2015	7	18	20	26	52	31	0	0	0	0	0	0	0	74.32	0	0	12
2015	7	18	20	36	52	31	0	0	0	0	0	0	0	74.19	0	0	12
2015	7	18	20	46	52	30	0	0	0	0	0	0	0	74.03	0	0	12
2015	7	18	20	56	52	31	0	0	0	0	0	0	0	73.87	0	0	12
2015	7	18	21	6	52	31	0	0	0	0	0	0	0	73.69	0	0	12
2015	7	18	21	16	52	30	0	0	0	0	0	0	0	73.51	0	0	12
2015	7	18	21	26	52	30	0	0	0	0	0	0	0	73.33	0	0	12
2015	7	18	21	36	52	30	0	0	0	0	0	0	0	73.17	0	0	12
2015	7	18	21	46	52	31	0	0	0	0	0	0	0	73	0	0	12
2015	7	18	21	56	52	30	0	0	0	0	0	0	0	72.88	0	0	12
2015	7	18	22	6	52	30	0	0	0	0	0	0	0	72.75	0	0	12
2015	7	18	22	16	52	31	0	0	0	0	0	0	0	72.63	0	0	12
2015	7	18	22	26	52	31	0	0	0	0	0	0	0	72.52	0	0	12
2015	7	18	22	36	52	31	0	0	0	0	0	0	0	72.41	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	18	22	46	52	31	0	0	0	0	0	0	0	72.28	0	0	12
2015	7	18	22	56	52	30	0	0	0	0	0	0	0	72.18	0	0	12
2015	7	18	23	6	52	30	0	0	0	0	0	0	0	72.05	0	0	12
2015	7	18	23	16	52	31	0	0	0	0	0	0	0	71.91	0	0	12
2015	7	18	23	26	52	31	0	0	0	0	0	0	0	71.8	0	0	12
2015	7	18	23	36	52	30	0	0	0	0	0	0	0	71.67	0	0	12
2015	7	18	23	46	52	31	0	0	0	0	0	0	0	71.55	0	0	12
2015	7	18	23	56	52	31	0	0	0	0	0	0	0	71.42	0	0	12
2015	7	19	0	6	52	31	0	0	0	0	0	0	0	71.29	0	0	12
2015	7	19	0	16	52	31	0	0	0	0	0	0	0	71.17	0	0	12
2015	7	19	0	26	52	32	0	0	0	0	0	0	0	71.04	0	0	12
2015	7	19	0	36	52	31	0	0	0	0	0	0	0	70.93	0	0	12
2015	7	19	0	46	52	31	0	0	0	0	0	0	0	70.81	0	0	12
2015	7	19	0	56	52	31	0	0	0	0	0	0	0	70.7	0	0	12
2015	7	19	1	6	52	31	0	0	0	0	0	0	0	70.59	0	0	12
2015	7	19	1	16	52	31	0	0	0	0	0	0	0	70.48	0	0	12
2015	7	19	1	26	52	31	0	0	0	0	0	0	0	70.38	0	0	12
2015	7	19	1	36	52	31	0	0	0	0	0	0	0	70.25	0	0	12
2015	7	19	1	46	52	31	0	0	0	0	0	0	0	70.16	0	0	12
2015	7	19	1	56	52	31	0	0	0	0	0	0	0	70.05	0	0	12
2015	7	19	2	6	52	31	0	0	0	0	0	0	0	69.96	0	0	12
2015	7	19	2	16	52	32	0	0	0	0	0	0	0	69.85	0	0	12
2015	7	19	2	26	52	31	0	0	0	0	0	0	0	69.78	0	0	12
2015	7	19	2	36	52	32	0	0	0	0	0	0	0	69.71	0	0	12
2015	7	19	2	46	52	31	0	0	0	0	0	0	0	69.64	0	0	12
2015	7	19	2	56	52	31	0	0	0	0	0	0	0	69.55	0	0	12
2015	7	19	3	6	52	31	0	0	0	0	0	0	0	69.48	0	0	12
2015	7	19	3	16	52	30	0	0	0	0	0	0	0	69.4	0	0	12
2015	7	19	3	26	52	31	0	0	0	0	0	0	0	69.33	0	0	12
2015	7	19	3	36	52	32	0	0	0	0	0	0	0	69.26	0	0	12
2015	7	19	3	46	52	31	0	0	0	0	0	0	0	69.17	0	0	12
2015	7	19	3	56	52	30	0	0	0	0	0	0	0	69.1	0	0	12
2015	7	19	4	6	52	31	0	0	0	0	0	0	0	69.04	0	0	12
2015	7	19	4	16	52	31	0	0	0	0	0	0	0	68.97	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	19	4	26	52	31	0	0	0	0	0	0	0	68.9	0	0	12
2015	7	19	4	36	52	31	0	0	0	0	0	0	0	68.85	0	0	11.8
2015	7	19	4	46	52	31	0	0	0	0	0	0	0	68.79	0	0	11.8
2015	7	19	4	56	52	31	0	0	0	0	0	0	0	68.74	0	0	11.8
2015	7	19	5	6	52	31	0	0	0	0	0	0	0	68.67	0	0	11.8
2015	7	19	5	16	52	31	0	0	0	0	0	0	0	68.63	0	0	11.8
2015	7	19	5	26	52	32	0	0	0	0	0	0	0	68.58	0	0	11.8
2015	7	19	5	36	52	31	0	0	0	0	0	0	0	68.54	0	0	11.8
2015	7	19	5	46	52	32	0	0	0	0	0	0	0	68.5	0	0	11.8
2015	7	19	5	56	52	31	0	0	0	0	0	0	0	68.47	0	0	11.8
2015	7	19	6	6	52	31	0	0	0	0	0	0	0	68.43	0	0	11.8
2015	7	19	6	16	52	31	0	0	0	0	0	0	0	68.43	0	0	12
2015	7	19	6	26	52	31	0	0	0	0	0	0	0	68.43	0	0	12
2015	7	19	6	36	52	31	0	0	0	0	0	0	0	68.43	0	0	12
2015	7	19	6	46	52	30	0	0	0	0	0	0	0	68.43	0	0	12
2015	7	19	6	56	52	31	0	0	0	0	0	0	0	68.41	0	0	12
2015	7	19	7	6	52	31	0	0	0	0	0	0	0	68.38	0	0	12
2015	7	19	7	16	52	31	0	0	0	0	0	0	0	68.4	0	0	12
2015	7	19	7	26	52	32	0	0	0	0	0	0	0	68.36	0	0	12
2015	7	19	7	36	52	31	0	0	0	0	0	0	0	68.38	0	0	12
2015	7	19	7	46	52	32	0	0	0	0	0	0	0	68.45	0	0	12.2
2015	7	19	7	56	52	30	0	0	0	0	0	0	0	68.67	0	0	12.4
2015	7	19	8	6	52	31	0	0	0	0	0	0	0	69.26	0	0	13
2015	7	19	8	16	52	31	0	0	0	0	0	0	0	69.44	0	0	13.2
2015	7	19	8	26	52	32	0	0	0	0	0	0	0	69.57	0	0	13.2
2015	7	19	8	36	52	31	0	0	0	0	0	0	0	69.58	0	0	13.2
2015	7	19	8	46	52	31	0	0	0	0	0	0	0	69.67	0	0	13.2
2015	7	19	8	56	52	31	0	0	0	0	0	0	0	69.76	0	0	13.2
2015	7	19	9	6	52	31	0	0	0	0	0	0	0	69.89	0	0	13.2
2015	7	19	9	16	52	31	0	0	0	0	0	0	0	70.03	0	0	13.2
2015	7	19	9	26	52	31	0	0	0	0	0	0	0	70.09	0	0	13.4
2015	7	19	9	36	52	32	0	0	0	0	0	0	0	70.25	0	0	13.2
2015	7	19	9	46	52	31	0	0	0	0	0	0	0	70.43	0	0	13.4
2015	7	19	9	56	52	31	0	0	0	0	0	0	0	70.61	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	19	10	6	52	31	0	0	0	0	0	0	0	70.74	0	0	13.4
2015	7	19	10	16	52	31	0	0	0	0	0	0	0	70.84	0	0	13.4
2015	7	19	10	26	52	31	0	0	0	0	0	0	0	71.04	0	0	13.4
2015	7	19	10	36	52	31	0	0	0	0	0	0	0	71.29	0	0	13.4
2015	7	19	10	46	52	31	0	0	0	0	0	0	0	71.51	0	0	13.4
2015	7	19	10	56	52	30	0	0	0	0	0	0	0	71.69	0	0	13.2
2015	7	19	11	6	52	31	0	0	0	0	0	0	0	71.83	0	0	13.2
2015	7	19	11	16	52	30	0	0	0	0	0	0	0	72.01	0	0	13.2
2015	7	19	11	26	52	31	0	0	0	0	0	0	0	72.25	0	0	13.2
2015	7	19	11	36	52	30	0	0	0	0	0	0	0	72.36	0	0	13.2
2015	7	19	11	46	52	31	0	0	0	0	0	0	0	71.73	0	0	13.2
2015	7	19	11	56	52	31	0	0	0	0	0	0	0	71.4	0	0	13.2
2015	7	19	12	6	52	31	0	0	0	0	0	0	0	71.47	0	0	13.2
2015	7	19	12	16	52	31	0	0	0	0	0	0	0	71.67	0	0	13.2
2015	7	19	12	26	52	31	0	0	0	0	0	0	0	71.92	0	0	13.2
2015	7	19	12	36	52	31	0	0	0	0	0	0	0	72.25	0	0	13.2
2015	7	19	12	46	52	31	0	0	0	0	0	0	0	72.61	0	0	13
2015	7	19	12	56	52	30	0	0	0	0	0	0	0	72.9	0	0	13
2015	7	19	13	6	52	31	0	0	0	0	0	0	0	73.11	0	0	13.2
2015	7	19	13	16	52	31	0	0	0	0	0	0	0	73.35	0	0	13.2
2015	7	19	13	26	52	31	0	0	0	0	0	0	0	74.26	0	0	13.2
2015	7	19	13	36	52	30	0	0	0	0	0	0	0	74.46	0	0	13.2
2015	7	19	13	46	52	31	0	0	0	0	0	0	0	74.64	0	0	13.2
2015	7	19	13	56	52	30	0	0	0	0	0	0	0	74.84	0	0	13.2
2015	7	19	14	6	52	30	0	0	0	0	0	0	0	75.04	0	0	13.2
2015	7	19	14	16	52	31	0	0	0	0	0	0	0	75.29	0	0	13.2
2015	7	19	14	26	52	31	0	0	0	0	0	0	0	75.58	0	0	13.2
2015	7	19	14	36	52	30	0	0	0	0	0	0	0	75.65	0	0	13
2015	7	19	14	46	52	31	0	0	0	0	0	0	0	75.67	0	0	13.2
2015	7	19	14	56	52	30	0	0	0	0	0	0	0	75.83	0	0	13.2
2015	7	19	15	6	52	31	0	0	0	0	0	0	0	75.7	0	0	12.8
2015	7	19	15	16	52	30	0	0	0	0	0	0	0	76.19	0	0	13
2015	7	19	15	26	52	31	0	0	0	0	0	0	0	76.42	0	0	13.2
2015	7	19	15	36	52	30	0	0	0	0	0	0	0	76.59	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	19	15	46	52	30	0	0	0	0	0	0	0	76.69	0	0	13.2
2015	7	19	15	56	52	29	0	0	0	0	0	0	0	76.8	0	0	13
2015	7	19	16	6	52	30	0	0	0	0	0	0	0	76.41	0	0	12.6
2015	7	19	16	16	52	31	0	0	0	0	0	0	0	76.84	0	0	12.8
2015	7	19	16	26	52	30	0	0	0	0	0	0	0	76.6	0	0	12.6
2015	7	19	16	36	52	30	0	0	0	0	0	0	0	76.75	0	0	12.4
2015	7	19	16	46	52	30	0	0	0	0	0	0	0	76.82	0	0	12.4
2015	7	19	16	56	52	30	0	0	0	0	0	0	0	77.05	0	0	12.4
2015	7	19	17	6	52	30	0	0	0	0	0	0	0	76.8	0	0	12.4
2015	7	19	17	16	52	30	0	0	0	0	0	0	0	76.73	0	0	12.2
2015	7	19	17	26	52	30	0	0	0	0	0	0	0	76.71	0	0	12.2
2015	7	19	17	36	52	30	0	0	0	0	0	0	0	76.77	0	0	12.2
2015	7	19	17	46	52	31	0	0	0	0	0	0	0	76.8	0	0	12.2
2015	7	19	17	56	52	30	0	0	0	0	0	0	0	76.82	0	0	12.2
2015	7	19	18	6	52	31	0	0	0	0	0	0	0	76.8	0	0	12.2
2015	7	19	18	16	52	30	0	0	0	0	0	0	0	76.8	0	0	12.2
2015	7	19	18	26	52	30	0	0	0	0	0	0	0	76.78	0	0	12.2
2015	7	19	18	36	52	31	0	0	0	0	0	0	0	76.77	0	0	12.2
2015	7	19	18	46	52	30	0	0	0	0	0	0	0	76.77	0	0	12.2
2015	7	19	18	56	52	30	0	0	0	0	0	0	0	76.73	0	0	12.2
2015	7	19	19	6	52	30	0	0	0	0	0	0	0	76.71	0	0	12.2
2015	7	19	19	16	52	30	0	0	0	0	0	0	0	76.68	0	0	12.2
2015	7	19	19	26	52	30	0	0	0	0	0	0	0	76.66	0	0	12.2
2015	7	19	19	36	52	30	0	0	0	0	0	0	0	76.6	0	0	12.2
2015	7	19	19	46	52	30	0	0	0	0	0	0	0	76.55	0	0	12.2
2015	7	19	19	56	52	30	0	0	0	0	0	0	0	76.46	0	0	12.2
2015	7	19	20	6	52	30	0	0	0	0	0	0	0	76.35	0	0	12.2
2015	7	19	20	16	52	30	0	0	0	0	0	0	0	76.24	0	0	12
2015	7	19	20	26	52	31	0	0	0	0	0	0	0	76.12	0	0	12
2015	7	19	20	36	52	31	0	0	0	0	0	0	0	75.99	0	0	12
2015	7	19	20	46	52	30	0	0	0	0	0	0	0	75.88	0	0	12
2015	7	19	20	56	52	30	0	0	0	0	0	0	0	75.76	0	0	12
2015	7	19	21	6	52	30	0	0	0	0	0	0	0	75.67	0	0	12
2015	7	19	21	16	52	30	0	0	0	0	0	0	0	75.58	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	19	21	26	52	30	0	0	0	0	0	0	0	75.51	0	0	12
2015	7	19	21	36	52	30	0	0	0	0	0	0	0	75.42	0	0	12
2015	7	19	21	46	52	30	0	0	0	0	0	0	0	75.34	0	0	12
2015	7	19	21	56	52	30	0	0	0	0	0	0	0	75.27	0	0	12
2015	7	19	22	6	52	30	0	0	0	0	0	0	0	75.2	0	0	12
2015	7	19	22	16	52	31	0	0	0	0	0	0	0	75.11	0	0	12
2015	7	19	22	26	52	30	0	0	0	0	0	0	0	75	0	0	12
2015	7	19	22	36	52	30	0	0	0	0	0	0	0	74.91	0	0	12
2015	7	19	22	46	52	30	0	0	0	0	0	0	0	74.82	0	0	12
2015	7	19	22	56	52	30	0	0	0	0	0	0	0	74.73	0	0	12
2015	7	19	23	6	52	31	0	0	0	0	0	0	0	74.64	0	0	12
2015	7	19	23	16	52	30	0	0	0	0	0	0	0	74.55	0	0	12
2015	7	19	23	26	52	30	0	0	0	0	0	0	0	74.48	0	0	12
2015	7	19	23	36	52	30	0	0	0	0	0	0	0	74.41	0	0	12
2015	7	19	23	46	52	30	0	0	0	0	0	0	0	74.34	0	0	12
2015	7	19	23	56	52	31	0	0	0	0	0	0	0	74.26	0	0	12
2015	7	20	0	6	52	30	0	0	0	0	0	0	0	74.21	0	0	12
2015	7	20	0	16	52	31	0	0	0	0	0	0	0	74.12	0	0	12
2015	7	20	0	26	52	31	0	0	0	0	0	0	0	74.05	0	0	12
2015	7	20	0	36	52	31	0	0	0	0	0	0	0	73.98	0	0	12
2015	7	20	0	46	52	30	0	0	0	0	0	0	0	73.89	0	0	12
2015	7	20	0	56	52	31	0	0	0	0	0	0	0	73.81	0	0	12
2015	7	20	1	6	52	31	0	0	0	0	0	0	0	73.74	0	0	12
2015	7	20	1	16	52	30	0	0	0	0	0	0	0	73.67	0	0	12
2015	7	20	1	26	52	31	0	0	0	0	0	0	0	73.6	0	0	12
2015	7	20	1	36	52	30	0	0	0	0	0	0	0	73.51	0	0	12
2015	7	20	1	46	52	31	0	0	0	0	0	0	0	73.44	0	0	12
2015	7	20	1	56	52	31	0	0	0	0	0	0	0	73.35	0	0	12
2015	7	20	2	6	52	30	0	0	0	0	0	0	0	73.27	0	0	12
2015	7	20	2	16	52	31	0	0	0	0	0	0	0	73.18	0	0	12
2015	7	20	2	26	52	31	0	0	0	0	0	0	0	73.11	0	0	12
2015	7	20	2	36	52	30	0	0	0	0	0	0	0	73.02	0	0	12
2015	7	20	2	46	52	31	0	0	0	0	0	0	0	72.95	0	0	12
2015	7	20	2	56	52	31	0	0	0	0	0	0	0	72.88	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	20	3	6	52	30	0	0	0	0	0	0	0	72.81	0	0	12
2015	7	20	3	16	52	31	0	0	0	0	0	0	0	72.73	0	0	12
2015	7	20	3	26	52	31	0	0	0	0	0	0	0	72.7	0	0	12
2015	7	20	3	36	52	30	0	0	0	0	0	0	0	72.63	0	0	12
2015	7	20	3	46	52	30	0	0	0	0	0	0	0	72.57	0	0	12
2015	7	20	3	56	52	31	0	0	0	0	0	0	0	72.52	0	0	12
2015	7	20	4	6	52	31	0	0	0	0	0	0	0	72.46	0	0	12
2015	7	20	4	16	52	31	0	0	0	0	0	0	0	72.41	0	0	12
2015	7	20	4	26	52	31	0	0	0	0	0	0	0	72.36	0	0	12
2015	7	20	4	36	52	30	0	0	0	0	0	0	0	72.28	0	0	12
2015	7	20	4	46	52	31	0	0	0	0	0	0	0	72.23	0	0	12
2015	7	20	4	56	52	30	0	0	0	0	0	0	0	72.18	0	0	12
2015	7	20	5	6	52	31	0	0	0	0	0	0	0	72.1	0	0	12
2015	7	20	5	16	52	31	0	0	0	0	0	0	0	72.03	0	0	12
2015	7	20	5	26	52	31	0	0	0	0	0	0	0	71.98	0	0	12
2015	7	20	5	36	52	30	0	0	0	0	0	0	0	71.92	0	0	12
2015	7	20	5	46	52	31	0	0	0	0	0	0	0	71.89	0	0	12
2015	7	20	5	56	52	31	0	0	0	0	0	0	0	71.85	0	0	12
2015	7	20	6	6	52	31	0	0	0	0	0	0	0	71.82	0	0	12
2015	7	20	6	16	52	31	0	0	0	0	0	0	0	71.8	0	0	12
2015	7	20	6	26	52	31	0	0	0	0	0	0	0	71.78	0	0	12
2015	7	20	6	36	52	31	0	0	0	0	0	0	0	71.74	0	0	12
2015	7	20	6	46	52	31	0	0	0	0	0	0	0	71.73	0	0	12
2015	7	20	6	56	52	31	0	0	0	0	0	0	0	71.71	0	0	12
2015	7	20	7	6	52	31	0	0	0	0	0	0	0	71.67	0	0	12
2015	7	20	7	16	52	30	0	0	0	0	0	0	0	71.65	0	0	12
2015	7	20	7	26	52	31	0	0	0	0	0	0	0	71.65	0	0	12
2015	7	20	7	36	52	30	0	0	0	0	0	0	0	71.67	0	0	12
2015	7	20	7	46	52	31	0	0	0	0	0	0	0	71.67	0	0	12
2015	7	20	7	56	52	30	0	0	0	0	0	0	0	71.65	0	0	12
2015	7	20	8	6	52	31	0	0	0	0	0	0	0	71.67	0	0	12
2015	7	20	8	16	52	31	0	0	0	0	0	0	0	71.65	0	0	12
2015	7	20	8	26	52	31	0	0	0	0	0	0	0	71.67	0	0	12.2
2015	7	20	8	36	52	30	0	0	0	0	0	0	0	71.78	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	20	8	46	52	30	0	0	0	0	0	0	0	71.92	0	0	12.6
2015	7	20	8	56	52	31	0	0	0	0	0	0	0	72.18	0	0	12.8
2015	7	20	9	6	52	31	0	0	0	0	0	0	0	72.21	0	0	12.8
2015	7	20	9	16	52	31	0	0	0	0	0	0	0	72.09	0	0	12.8
2015	7	20	9	26	52	31	0	0	0	0	0	0	0	72.05	0	0	12.6
2015	7	20	9	36	52	31	0	0	0	0	0	0	0	72.09	0	0	12.6
2015	7	20	9	46	52	30	0	0	0	0	0	0	0	72.1	0	0	12.6
2015	7	20	9	56	52	31	0	0	0	0	0	0	0	72.12	0	0	12.6
2015	7	20	10	6	52	30	0	0	0	0	0	0	0	72	0	0	12.6
2015	7	20	10	16	52	31	0	0	0	0	0	0	0	71.92	0	0	12.6
2015	7	20	10	26	52	30	0	0	0	0	0	0	0	71.94	0	0	12.4
2015	7	20	10	36	52	31	0	0	0	0	0	0	0	71.98	0	0	12.4
2015	7	20	10	46	52	31	0	0	0	0	0	0	0	72	0	0	12.6
2015	7	20	10	56	52	31	0	0	0	0	0	0	0	72.1	0	0	12.6
2015	7	20	11	6	52	32	0	0	0	0	0	0	0	72.21	0	0	12.8
2015	7	20	11	16	52	31	0	0	0	0	0	0	0	72.25	0	0	12.8
2015	7	20	11	26	52	31	0	0	0	0	0	0	0	72.32	0	0	12.8
2015	7	20	11	36	52	31	0	0	0	0	0	0	0	72.45	0	0	13
2015	7	20	11	46	52	31	0	0	0	0	0	0	0	72.57	0	0	13.4
2015	7	20	11	56	52	31	0	0	0	0	0	0	0	72.52	0	0	12.8
2015	7	20	12	6	52	31	0	0	0	0	0	0	0	72.63	0	0	13.2
2015	7	20	12	16	52	31	0	0	0	0	0	0	0	72.72	0	0	13.4
2015	7	20	12	26	52	30	0	0	0	0	0	0	0	72.84	0	0	13.2
2015	7	20	12	36	52	30	0	0	0	0	0	0	0	73.02	0	0	13.2
2015	7	20	12	46	52	31	0	0	0	0	0	0	0	73.15	0	0	13.2
2015	7	20	12	56	52	31	0	0	0	0	0	0	0	73.33	0	0	13.4
2015	7	20	13	6	52	31	0	0	0	0	0	0	0	73.69	0	0	13.2
2015	7	20	13	16	52	31	0	0	0	0	0	0	0	74.03	0	0	13
2015	7	20	13	26	52	31	0	0	0	0	0	0	0	74.12	0	0	13.2
2015	7	20	13	36	52	31	0	0	0	0	0	0	0	74.28	0	0	13
2015	7	20	13	46	52	30	0	0	0	0	0	0	0	73.99	0	0	12.8
2015	7	20	13	56	52	31	0	0	0	0	0	0	0	74.03	0	0	12.8
2015	7	20	14	6	52	31	0	0	0	0	0	0	0	74.21	0	0	13
2015	7	20	14	16	52	31	0	0	0	0	0	0	0	74.17	0	0	12.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	20	14	26	52	31	0	0	0	0	0	0	0	74.12	0	0	12.8
2015	7	20	14	36	52	31	0	0	0	0	0	0	0	74.19	0	0	12.6
2015	7	20	14	46	52	30	0	0	0	0	0	0	0	74.23	0	0	12.8
2015	7	20	14	56	52	31	0	0	0	0	0	0	0	74.39	0	0	13
2015	7	20	15	6	52	31	0	0	0	0	0	0	0	74.57	0	0	13
2015	7	20	15	16	52	30	0	0	0	0	0	0	0	74.39	0	0	12.8
2015	7	20	15	26	52	30	0	0	0	0	0	0	0	74.32	0	0	12.6
2015	7	20	15	36	52	30	0	0	0	0	0	0	0	74.32	0	0	12.4
2015	7	20	15	46	52	31	0	0	0	0	0	0	0	74.39	0	0	12.4
2015	7	20	15	56	52	30	0	0	0	0	0	0	0	74.46	0	0	12.4
2015	7	20	16	6	52	31	0	0	0	0	0	0	0	74.57	0	0	12.6
2015	7	20	16	16	52	31	0	0	0	0	0	0	0	74.62	0	0	12.6
2015	7	20	16	26	52	30	0	0	0	0	0	0	0	74.66	0	0	12.6
2015	7	20	16	36	52	30	0	0	0	0	0	0	0	74.66	0	0	12.4
2015	7	20	16	46	52	30	0	0	0	0	0	0	0	74.66	0	0	12.4
2015	7	20	16	56	52	31	0	0	0	0	0	0	0	74.68	0	0	12.4
2015	7	20	17	6	52	31	0	0	0	0	0	0	0	74.7	0	0	12.4
2015	7	20	17	16	52	30	0	0	0	0	0	0	0	74.73	0	0	12.4
2015	7	20	17	26	52	31	0	0	0	0	0	0	0	74.82	0	0	12.4
2015	7	20	17	36	52	31	0	0	0	0	0	0	0	74.97	0	0	12.4
2015	7	20	17	46	52	31	0	0	0	0	0	0	0	74.86	0	0	12.4
2015	7	20	17	56	52	30	0	0	0	0	0	0	0	74.84	0	0	12.4
2015	7	20	18	6	52	30	0	0	0	0	0	0	0	74.82	0	0	12.4
2015	7	20	18	16	52	30	0	0	0	0	0	0	0	74.89	0	0	12.4
2015	7	20	18	26	52	30	0	0	0	0	0	0	0	74.86	0	0	12.4
2015	7	20	18	36	52	30	0	0	0	0	0	0	0	74.82	0	0	12.2
2015	7	20	18	46	52	31	0	0	0	0	0	0	0	74.8	0	0	12.2
2015	7	20	18	56	52	31	0	0	0	0	0	0	0	74.8	0	0	12.2
2015	7	20	19	6	52	30	0	0	0	0	0	0	0	74.75	0	0	12.2
2015	7	20	19	16	52	31	0	0	0	0	0	0	0	74.7	0	0	12.2
2015	7	20	19	26	52	31	0	0	0	0	0	0	0	74.66	0	0	12.2
2015	7	20	19	36	52	30	0	0	0	0	0	0	0	74.61	0	0	12.2
2015	7	20	19	46	52	30	0	0	0	0	0	0	0	74.55	0	0	12.2
2015	7	20	19	56	52	31	0	0	0	0	0	0	0	74.53	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	20	20	6	52	31	0	0	0	0	0	0	0	74.5	0	0	12
2015	7	20	20	16	52	30	0	0	0	0	0	0	0	74.5	0	0	12
2015	7	20	20	26	52	30	0	0	0	0	0	0	0	74.48	0	0	12
2015	7	20	20	36	52	31	0	0	0	0	0	0	0	74.48	0	0	12
2015	7	20	20	46	52	30	0	0	0	0	0	0	0	74.44	0	0	12
2015	7	20	20	56	52	30	0	0	0	0	0	0	0	74.39	0	0	12
2015	7	20	21	6	52	30	0	0	0	0	0	0	0	74.35	0	0	12
2015	7	20	21	16	52	30	0	0	0	0	0	0	0	74.3	0	0	12
2015	7	20	21	26	52	30	0	0	0	0	0	0	0	74.26	0	0	12
2015	7	20	21	36	52	30	0	0	0	0	0	0	0	74.21	0	0	12
2015	7	20	21	46	52	31	0	0	0	0	0	0	0	74.16	0	0	12
2015	7	20	21	56	52	30	0	0	0	0	0	0	0	74.1	0	0	12
2015	7	20	22	6	52	31	0	0	0	0	0	0	0	74.01	0	0	12
2015	7	20	22	16	52	31	0	0	0	0	0	0	0	73.89	0	0	12
2015	7	20	22	26	52	30	0	0	0	0	0	0	0	73.78	0	0	12
2015	7	20	22	36	52	30	0	0	0	0	0	0	0	73.63	0	0	12
2015	7	20	22	46	52	30	0	0	0	0	0	0	0	73.47	0	0	12
2015	7	20	22	56	52	30	0	0	0	0	0	0	0	73.29	0	0	12
2015	7	20	23	6	52	31	0	0	0	0	0	0	0	73.13	0	0	12
2015	7	20	23	16	52	30	0	0	0	0	0	0	0	73	0	0	12
2015	7	20	23	26	52	31	0	0	0	0	0	0	0	72.88	0	0	12
2015	7	20	23	36	52	31	0	0	0	0	0	0	0	72.75	0	0	12
2015	7	20	23	46	52	31	0	0	0	0	0	0	0	72.66	0	0	12
2015	7	20	23	56	52	31	0	0	0	0	0	0	0	72.59	0	0	12
2015	7	21	0	6	52	30	0	0	0	0	0	0	0	72.52	0	0	12
2015	7	21	0	16	52	31	0	0	0	0	0	0	0	72.46	0	0	12
2015	7	21	0	26	52	30	0	0	0	0	0	0	0	72.41	0	0	12
2015	7	21	0	36	52	31	0	0	0	0	0	0	0	72.34	0	0	12
2015	7	21	0	46	52	31	0	0	0	0	0	0	0	72.28	0	0	12
2015	7	21	0	56	52	31	0	0	0	0	0	0	0	72.21	0	0	12
2015	7	21	1	6	52	30	0	0	0	0	0	0	0	72.14	0	0	12
2015	7	21	1	16	52	31	0	0	0	0	0	0	0	72.07	0	0	12
2015	7	21	1	26	52	30	0	0	0	0	0	0	0	72	0	0	12
2015	7	21	1	36	52	31	0	0	0	0	0	0	0	71.92	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	21	1	46	52	31	0	0	0	0	0	0	0	71.85	0	0	12
2015	7	21	1	56	52	31	0	0	0	0	0	0	0	71.78	0	0	12
2015	7	21	2	6	52	30	0	0	0	0	0	0	0	71.71	0	0	12
2015	7	21	2	16	52	31	0	0	0	0	0	0	0	71.65	0	0	12
2015	7	21	2	26	52	31	0	0	0	0	0	0	0	71.58	0	0	12
2015	7	21	2	36	52	31	0	0	0	0	0	0	0	71.53	0	0	12
2015	7	21	2	46	52	31	0	0	0	0	0	0	0	71.46	0	0	12
2015	7	21	2	56	52	30	0	0	0	0	0	0	0	71.4	0	0	12
2015	7	21	3	6	52	31	0	0	0	0	0	0	0	71.33	0	0	12
2015	7	21	3	16	52	31	0	0	0	0	0	0	0	71.28	0	0	11.8
2015	7	21	3	26	52	32	0	0	0	0	0	0	0	71.22	0	0	11.8
2015	7	21	3	36	52	30	0	0	0	0	0	0	0	71.15	0	0	11.8
2015	7	21	3	46	52	31	0	0	0	0	0	0	0	71.1	0	0	11.8
2015	7	21	3	56	52	31	0	0	0	0	0	0	0	71.02	0	0	11.8
2015	7	21	4	6	52	31	0	0	0	0	0	0	0	70.97	0	0	11.8
2015	7	21	4	16	52	31	0	0	0	0	0	0	0	70.92	0	0	11.8
2015	7	21	4	26	52	31	0	0	0	0	0	0	0	70.86	0	0	11.8
2015	7	21	4	36	52	31	0	0	0	0	0	0	0	70.81	0	0	11.8
2015	7	21	4	46	52	31	0	0	0	0	0	0	0	70.75	0	0	11.8
2015	7	21	4	56	52	31	0	0	0	0	0	0	0	70.72	0	0	11.8
2015	7	21	5	6	52	31	0	0	0	0	0	0	0	70.66	0	0	11.8
2015	7	21	5	16	52	31	0	0	0	0	0	0	0	70.63	0	0	11.8
2015	7	21	5	26	52	31	0	0	0	0	0	0	0	70.57	0	0	11.8
2015	7	21	5	36	52	31	0	0	0	0	0	0	0	70.52	0	0	11.8
2015	7	21	5	46	52	31	0	0	0	0	0	0	0	70.47	0	0	11.8
2015	7	21	5	56	52	31	0	0	0	0	0	0	0	70.41	0	0	11.8
2015	7	21	6	6	52	31	0	0	0	0	0	0	0	70.36	0	0	11.8
2015	7	21	6	16	52	30	0	0	0	0	0	0	0	70.32	0	0	12
2015	7	21	6	26	52	30	0	0	0	0	0	0	0	70.3	0	0	12
2015	7	21	6	36	52	31	0	0	0	0	0	0	0	70.27	0	0	12
2015	7	21	6	46	52	31	0	0	0	0	0	0	0	70.23	0	0	12
2015	7	21	6	56	52	30	0	0	0	0	0	0	0	70.18	0	0	12
2015	7	21	7	6	52	31	0	0	0	0	0	0	0	70.2	0	0	12
2015	7	21	7	16	52	31	0	0	0	0	0	0	0	70.32	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	21	7	26	52	32	0	0	0	0	0	0	0	70.48	0	0	12.4
2015	7	21	7	36	52	30	0	0	0	0	0	0	0	70.34	0	0	12.2
2015	7	21	7	46	52	30	0	0	0	0	0	0	0	70.27	0	0	12.2
2015	7	21	7	56	52	31	0	0	0	0	0	0	0	70.41	0	0	12.4
2015	7	21	8	6	52	30	0	0	0	0	0	0	0	70.43	0	0	12.6
2015	7	21	8	16	52	31	0	0	0	0	0	0	0	70.77	0	0	13
2015	7	21	8	26	52	31	0	0	0	0	0	0	0	70.97	0	0	13
2015	7	21	8	36	52	31	0	0	0	0	0	0	0	71.06	0	0	13.2
2015	7	21	8	46	52	31	0	0	0	0	0	0	0	70.97	0	0	13
2015	7	21	8	56	52	32	0	0	0	0	0	0	0	71.17	0	0	13.2
2015	7	21	9	6	52	31	0	0	0	0	0	0	0	71.33	0	0	13.2
2015	7	21	9	16	52	31	0	0	0	0	0	0	0	71.42	0	0	13.2
2015	7	21	9	26	52	31	0	0	0	0	0	0	0	71.53	0	0	13.2
2015	7	21	9	36	52	31	0	0	0	0	0	0	0	71.6	0	0	13.4
2015	7	21	9	46	52	31	0	0	0	0	0	0	0	71.73	0	0	13.4
2015	7	21	9	56	52	31	0	0	0	0	0	0	0	71.87	0	0	13.4
2015	7	21	10	6	52	31	0	0	0	0	0	0	0	72.01	0	0	13.4
2015	7	21	10	16	52	31	0	0	0	0	0	0	0	72.21	0	0	13.4
2015	7	21	10	26	52	30	0	0	0	0	0	0	0	72.07	0	0	13.4
2015	7	21	10	36	52	31	0	0	0	0	0	0	0	72.43	0	0	13.4
2015	7	21	10	46	52	30	0	0	0	0	0	0	0	72.57	0	0	13.4
2015	7	21	10	56	52	30	0	0	0	0	0	0	0	72.77	0	0	13.4
2015	7	21	11	6	52	31	0	0	0	0	0	0	0	73	0	0	13.4
2015	7	21	11	16	52	31	0	0	0	0	0	0	0	73.09	0	0	13.4
2015	7	21	11	26	52	31	0	0	0	0	0	0	0	73.24	0	0	13.4
2015	7	21	11	36	52	30	0	0	0	0	0	0	0	73.42	0	0	13.4
2015	7	21	11	46	52	31	0	0	0	0	0	0	0	72.72	0	0	13.4
2015	7	21	11	56	52	31	0	0	0	0	0	0	0	72.37	0	0	13.4
2015	7	21	12	6	52	31	0	0	0	0	0	0	0	72.43	0	0	13.4
2015	7	21	12	16	52	31	0	0	0	0	0	0	0	72.63	0	0	13.4
2015	7	21	12	26	52	31	0	0	0	0	0	0	0	72.86	0	0	13.4
2015	7	21	12	36	52	31	0	0	0	0	0	0	0	73.11	0	0	13.4
2015	7	21	12	46	52	31	0	0	0	0	0	0	0	73.35	0	0	13.4
2015	7	21	12	56	52	30	0	0	0	0	0	0	0	73.62	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	21	13	6	52	31	0	0	0	0	0	0	0	74.16	0	0	13.4
2015	7	21	13	16	52	31	0	0	0	0	0	0	0	75.33	0	0	13.4
2015	7	21	13	26	52	31	0	0	0	0	0	0	0	75.79	0	0	13.2
2015	7	21	13	36	52	30	0	0	0	0	0	0	0	76.15	0	0	13.2
2015	7	21	13	46	52	31	0	0	0	0	0	0	0	76.42	0	0	13.2
2015	7	21	13	56	52	31	0	0	0	0	0	0	0	76.71	0	0	13.2
2015	7	21	14	6	52	31	0	0	0	0	0	0	0	77	0	0	13.2
2015	7	21	14	16	52	30	0	0	0	0	0	0	0	77.2	0	0	13.2
2015	7	21	14	26	52	30	0	0	0	0	0	0	0	77.38	0	0	13.2
2015	7	21	14	36	52	31	0	0	0	0	0	0	0	77.54	0	0	13.2
2015	7	21	14	46	52	30	0	0	0	0	0	0	0	77.72	0	0	13.2
2015	7	21	14	56	52	30	0	0	0	0	0	0	0	77.88	0	0	13.2
2015	7	21	15	6	52	30	0	0	0	0	0	0	0	78.08	0	0	13.2
2015	7	21	15	16	52	30	0	0	0	0	0	0	0	77.88	0	0	12.8
2015	7	21	15	26	52	29	0	0	0	0	0	0	0	77.61	0	0	12.6
2015	7	21	15	36	52	30	0	0	0	0	0	0	0	77.77	0	0	12.6
2015	7	21	15	46	52	30	0	0	0	0	0	0	0	77.67	0	0	12.6
2015	7	21	15	56	52	30	0	0	0	0	0	0	0	77.7	0	0	12.6
2015	7	21	16	6	52	30	0	0	0	0	0	0	0	77.79	0	0	12.6
2015	7	21	16	16	52	30	0	0	0	0	0	0	0	77.85	0	0	12.6
2015	7	21	16	26	52	30	0	0	0	0	0	0	0	77.86	0	0	12.6
2015	7	21	16	36	52	30	0	0	0	0	0	0	0	77.9	0	0	12.4
2015	7	21	16	46	52	30	0	0	0	0	0	0	0	77.9	0	0	12.4
2015	7	21	16	56	52	30	0	0	0	0	0	0	0	77.9	0	0	12.4
2015	7	21	17	6	52	31	0	0	0	0	0	0	0	77.86	0	0	12.4
2015	7	21	17	16	52	30	0	0	0	0	0	0	0	77.81	0	0	12.2
2015	7	21	17	26	52	30	0	0	0	0	0	0	0	77.81	0	0	12.2
2015	7	21	17	36	52	31	0	0	0	0	0	0	0	77.83	0	0	12.2
2015	7	21	17	46	52	30	0	0	0	0	0	0	0	77.86	0	0	12.2
2015	7	21	17	56	52	30	0	0	0	0	0	0	0	77.88	0	0	12.2
2015	7	21	18	6	52	30	0	0	0	0	0	0	0	77.83	0	0	12.2
2015	7	21	18	16	52	30	0	0	0	0	0	0	0	77.81	0	0	12.2
2015	7	21	18	26	52	30	0	0	0	0	0	0	0	77.77	0	0	12.2
2015	7	21	18	36	52	30	0	0	0	0	0	0	0	77.72	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	21	18	46	52	30	0	0	0	0	0	0	0	77.7	0	0	12.2
2015	7	21	18	56	52	30	0	0	0	0	0	0	0	77.67	0	0	12.2
2015	7	21	19	6	52	30	0	0	0	0	0	0	0	77.63	0	0	12.2
2015	7	21	19	16	52	29	0	0	0	0	0	0	0	77.58	0	0	12.2
2015	7	21	19	26	52	30	0	0	0	0	0	0	0	77.54	0	0	12.2
2015	7	21	19	36	52	30	0	0	0	0	0	0	0	77.5	0	0	12.2
2015	7	21	19	46	52	30	0	0	0	0	0	0	0	77.47	0	0	12.2
2015	7	21	19	56	52	30	0	0	0	0	0	0	0	77.41	0	0	12.2
2015	7	21	20	6	52	30	0	0	0	0	0	0	0	77.34	0	0	12.2
2015	7	21	20	16	52	30	0	0	0	0	0	0	0	77.25	0	0	12
2015	7	21	20	26	52	30	0	0	0	0	0	0	0	77.16	0	0	12
2015	7	21	20	36	52	30	0	0	0	0	0	0	0	77.07	0	0	12
2015	7	21	20	46	52	30	0	0	0	0	0	0	0	76.96	0	0	12
2015	7	21	20	56	52	30	0	0	0	0	0	0	0	76.86	0	0	12
2015	7	21	21	6	52	30	0	0	0	0	0	0	0	76.77	0	0	12
2015	7	21	21	16	52	30	0	0	0	0	0	0	0	76.66	0	0	12
2015	7	21	21	26	52	30	0	0	0	0	0	0	0	76.57	0	0	12
2015	7	21	21	36	52	30	0	0	0	0	0	0	0	76.48	0	0	12
2015	7	21	21	46	52	30	0	0	0	0	0	0	0	76.37	0	0	12
2015	7	21	21	56	52	30	0	0	0	0	0	0	0	76.26	0	0	12
2015	7	21	22	6	52	30	0	0	0	0	0	0	0	76.17	0	0	12
2015	7	21	22	16	52	31	0	0	0	0	0	0	0	76.08	0	0	12
2015	7	21	22	26	52	30	0	0	0	0	0	0	0	75.96	0	0	12
2015	7	21	22	36	52	31	0	0	0	0	0	0	0	75.85	0	0	12
2015	7	21	22	46	52	31	0	0	0	0	0	0	0	75.72	0	0	12
2015	7	21	22	56	52	31	0	0	0	0	0	0	0	75.58	0	0	12
2015	7	21	23	6	52	30	0	0	0	0	0	0	0	75.43	0	0	12
2015	7	21	23	16	52	31	0	0	0	0	0	0	0	75.29	0	0	12
2015	7	21	23	26	52	30	0	0	0	0	0	0	0	75.16	0	0	12
2015	7	21	23	36	52	30	0	0	0	0	0	0	0	75.02	0	0	12
2015	7	21	23	46	52	30	0	0	0	0	0	0	0	74.89	0	0	12
2015	7	21	23	56	52	30	0	0	0	0	0	0	0	74.75	0	0	12
2015	7	22	0	6	52	30	0	0	0	0	0	0	0	74.59	0	0	12
2015	7	22	0	16	52	29	0	0	0	0	0	0	0	74.44	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	22	0	26	52	30	0	0	0	0	0	0	0	74.28	0	0	12
2015	7	22	0	36	52	30	0	0	0	0	0	0	0	74.16	0	0	12
2015	7	22	0	46	52	30	0	0	0	0	0	0	0	74.01	0	0	12
2015	7	22	0	56	52	31	0	0	0	0	0	0	0	73.89	0	0	12
2015	7	22	1	6	52	31	0	0	0	0	0	0	0	73.76	0	0	12
2015	7	22	1	16	52	31	0	0	0	0	0	0	0	73.63	0	0	12
2015	7	22	1	26	52	30	0	0	0	0	0	0	0	73.51	0	0	12
2015	7	22	1	36	52	31	0	0	0	0	0	0	0	73.38	0	0	12
2015	7	22	1	46	52	30	0	0	0	0	0	0	0	73.27	0	0	12
2015	7	22	1	56	52	31	0	0	0	0	0	0	0	73.17	0	0	12
2015	7	22	2	6	52	31	0	0	0	0	0	0	0	73.06	0	0	12
2015	7	22	2	16	52	30	0	0	0	0	0	0	0	72.95	0	0	12
2015	7	22	2	26	52	30	0	0	0	0	0	0	0	72.84	0	0	12
2015	7	22	2	36	52	30	0	0	0	0	0	0	0	72.75	0	0	12
2015	7	22	2	46	52	30	0	0	0	0	0	0	0	72.66	0	0	12
2015	7	22	2	56	52	30	0	0	0	0	0	0	0	72.57	0	0	12
2015	7	22	3	6	52	31	0	0	0	0	0	0	0	72.46	0	0	12
2015	7	22	3	16	52	30	0	0	0	0	0	0	0	72.39	0	0	12
2015	7	22	3	26	52	30	0	0	0	0	0	0	0	72.32	0	0	12
2015	7	22	3	36	52	31	0	0	0	0	0	0	0	72.25	0	0	12
2015	7	22	3	46	52	31	0	0	0	0	0	0	0	72.18	0	0	12
2015	7	22	3	56	52	30	0	0	0	0	0	0	0	72.09	0	0	12
2015	7	22	4	6	52	30	0	0	0	0	0	0	0	72.01	0	0	12
2015	7	22	4	16	52	31	0	0	0	0	0	0	0	71.92	0	0	12
2015	7	22	4	26	52	30	0	0	0	0	0	0	0	71.85	0	0	12
2015	7	22	4	36	52	31	0	0	0	0	0	0	0	71.78	0	0	12
2015	7	22	4	46	52	30	0	0	0	0	0	0	0	71.69	0	0	12
2015	7	22	4	56	52	31	0	0	0	0	0	0	0	71.6	0	0	12
2015	7	22	5	6	52	31	0	0	0	0	0	0	0	71.51	0	0	12
2015	7	22	5	16	52	31	0	0	0	0	0	0	0	71.44	0	0	12
2015	7	22	5	26	52	31	0	0	0	0	0	0	0	71.37	0	0	12
2015	7	22	5	36	52	31	0	0	0	0	0	0	0	71.28	0	0	12
2015	7	22	5	46	52	32	0	0	0	0	0	0	0	71.2	0	0	12
2015	7	22	5	56	52	31	0	0	0	0	0	0	0	71.15	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	22	6	6	52	31	0	0	0	0	0	0	0	71.1	0	0	12
2015	7	22	6	16	52	31	0	0	0	0	0	0	0	71.02	0	0	12
2015	7	22	6	26	52	31	0	0	0	0	0	0	0	70.97	0	0	12
2015	7	22	6	36	52	31	0	0	0	0	0	0	0	70.9	0	0	12
2015	7	22	6	46	52	31	0	0	0	0	0	0	0	70.84	0	0	12
2015	7	22	6	56	52	31	0	0	0	0	0	0	0	70.9	0	0	12.2
2015	7	22	7	6	52	31	0	0	0	0	0	0	0	70.99	0	0	12.2
2015	7	22	7	16	52	31	0	0	0	0	0	0	0	71.04	0	0	12.4
2015	7	22	7	26	52	31	0	0	0	0	0	0	0	71.13	0	0	12.4
2015	7	22	7	36	52	31	0	0	0	0	0	0	0	71.22	0	0	12.6
2015	7	22	7	46	52	31	0	0	0	0	0	0	0	71.31	0	0	12.8
2015	7	22	7	56	52	31	0	0	0	0	0	0	0	71.38	0	0	12.8
2015	7	22	8	6	52	31	0	0	0	0	0	0	0	71.49	0	0	13
2015	7	22	8	16	52	31	0	0	0	0	0	0	0	71.6	0	0	13
2015	7	22	8	26	52	31	0	0	0	0	0	0	0	71.73	0	0	13
2015	7	22	8	36	52	31	0	0	0	0	0	0	0	71.83	0	0	13
2015	7	22	8	46	52	31	0	0	0	0	0	0	0	71.96	0	0	13.2
2015	7	22	8	56	52	30	0	0	0	0	0	0	0	72.07	0	0	13.2
2015	7	22	9	6	52	31	0	0	0	0	0	0	0	72.19	0	0	13.2
2015	7	22	9	16	52	31	0	0	0	0	0	0	0	72.3	0	0	13.2
2015	7	22	9	26	52	30	0	0	0	0	0	0	0	72.41	0	0	13.2
2015	7	22	9	36	52	31	0	0	0	0	0	0	0	72.54	0	0	13.2
2015	7	22	9	46	52	31	0	0	0	0	0	0	0	72.66	0	0	13.2
2015	7	22	9	56	52	30	0	0	0	0	0	0	0	72.81	0	0	13.2
2015	7	22	10	6	52	31	0	0	0	0	0	0	0	72.93	0	0	13.2
2015	7	22	10	16	52	31	0	0	0	0	0	0	0	73.08	0	0	13.2
2015	7	22	10	26	52	30	0	0	0	0	0	0	0	73.24	0	0	13.2
2015	7	22	10	36	52	31	0	0	0	0	0	0	0	73.36	0	0	13.2
2015	7	22	10	46	52	31	0	0	0	0	0	0	0	73.53	0	0	13.2
2015	7	22	10	56	52	30	0	0	0	0	0	0	0	73.67	0	0	13.2
2015	7	22	11	6	52	31	0	0	0	0	0	0	0	73.81	0	0	13.2
2015	7	22	11	16	52	30	0	0	0	0	0	0	0	74.01	0	0	13.2
2015	7	22	11	26	52	31	0	0	0	0	0	0	0	74.16	0	0	13.2
2015	7	22	11	36	52	30	0	0	0	0	0	0	0	74.3	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	22	11	46	52	31	0	0	0	0	0	0	0	73.62	0	0	13.2
2015	7	22	11	56	52	30	0	0	0	0	0	0	0	73.47	0	0	13.2
2015	7	22	12	6	52	31	0	0	0	0	0	0	0	73.58	0	0	13.2
2015	7	22	12	16	52	30	0	0	0	0	0	0	0	73.81	0	0	13.2
2015	7	22	12	26	52	30	0	0	0	0	0	0	0	74.01	0	0	13.2
2015	7	22	12	36	52	31	0	0	0	0	0	0	0	74.23	0	0	13.2
2015	7	22	12	46	52	30	0	0	0	0	0	0	0	74.52	0	0	13.2
2015	7	22	12	56	52	30	0	0	0	0	0	0	0	74.82	0	0	13.2
2015	7	22	13	6	52	31	0	0	0	0	0	0	0	75.33	0	0	13.2
2015	7	22	13	16	52	30	0	0	0	0	0	0	0	75.61	0	0	13.2
2015	7	22	13	26	52	30	0	0	0	0	0	0	0	76.26	0	0	13.2
2015	7	22	13	36	52	30	0	0	0	0	0	0	0	76.51	0	0	13.2
2015	7	22	13	46	52	31	0	0	0	0	0	0	0	76.73	0	0	13.2
2015	7	22	13	56	52	31	0	0	0	0	0	0	0	76.89	0	0	13.2
2015	7	22	14	6	52	30	0	0	0	0	0	0	0	77.09	0	0	13.2
2015	7	22	14	16	52	30	0	0	0	0	0	0	0	77.31	0	0	13.2
2015	7	22	14	26	52	30	0	0	0	0	0	0	0	77.47	0	0	13.2
2015	7	22	14	36	52	29	0	0	0	0	0	0	0	77.36	0	0	13
2015	7	22	14	46	52	30	0	0	0	0	0	0	0	77.18	0	0	12.8
2015	7	22	14	56	52	30	0	0	0	0	0	0	0	77.34	0	0	12.8
2015	7	22	15	6	52	31	0	0	0	0	0	0	0	77.52	0	0	13
2015	7	22	15	16	52	30	0	0	0	0	0	0	0	77.47	0	0	12.8
2015	7	22	15	26	52	30	0	0	0	0	0	0	0	77.47	0	0	12.8
2015	7	22	15	36	52	30	0	0	0	0	0	0	0	77.52	0	0	12.8
2015	7	22	15	46	52	30	0	0	0	0	0	0	0	77.49	0	0	12.6
2015	7	22	15	56	52	30	0	0	0	0	0	0	0	77.43	0	0	12.6
2015	7	22	16	6	52	31	0	0	0	0	0	0	0	77.36	0	0	12.4
2015	7	22	16	16	52	30	0	0	0	0	0	0	0	77.29	0	0	12.4
2015	7	22	16	26	52	30	0	0	0	0	0	0	0	77.31	0	0	12.4
2015	7	22	16	36	52	31	0	0	0	0	0	0	0	77.23	0	0	12.2
2015	7	22	16	46	52	30	0	0	0	0	0	0	0	77.22	0	0	12.2
2015	7	22	16	56	52	30	0	0	0	0	0	0	0	77.18	0	0	12.2
2015	7	22	17	6	52	30	0	0	0	0	0	0	0	77.16	0	0	12.2
2015	7	22	17	16	52	30	0	0	0	0	0	0	0	77.18	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	22	17	26	52	30	0	0	0	0	0	0	0	77.2	0	0	12.2
2015	7	22	17	36	52	30	0	0	0	0	0	0	0	77.23	0	0	12.2
2015	7	22	17	46	52	30	0	0	0	0	0	0	0	77.27	0	0	12.2
2015	7	22	17	56	52	29	0	0	0	0	0	0	0	77.27	0	0	12.2
2015	7	22	18	6	52	30	0	0	0	0	0	0	0	77.31	0	0	12.2
2015	7	22	18	16	52	30	0	0	0	0	0	0	0	77.36	0	0	12.2
2015	7	22	18	26	52	30	0	0	0	0	0	0	0	77.38	0	0	12.2
2015	7	22	18	36	52	30	0	0	0	0	0	0	0	77.41	0	0	12.2
2015	7	22	18	46	52	30	0	0	0	0	0	0	0	77.41	0	0	12.2
2015	7	22	18	56	52	30	0	0	0	0	0	0	0	77.38	0	0	12.2
2015	7	22	19	6	52	30	0	0	0	0	0	0	0	77.38	0	0	12.2
2015	7	22	19	16	52	30	0	0	0	0	0	0	0	77.34	0	0	12.2
2015	7	22	19	26	52	30	0	0	0	0	0	0	0	77.29	0	0	12.2
2015	7	22	19	36	52	30	0	0	0	0	0	0	0	77.23	0	0	12.2
2015	7	22	19	46	52	30	0	0	0	0	0	0	0	77.16	0	0	12.2
2015	7	22	19	56	52	30	0	0	0	0	0	0	0	77.07	0	0	12
2015	7	22	20	6	52	30	0	0	0	0	0	0	0	76.98	0	0	12
2015	7	22	20	16	52	30	0	0	0	0	0	0	0	76.87	0	0	12
2015	7	22	20	26	52	30	0	0	0	0	0	0	0	76.78	0	0	12
2015	7	22	20	36	52	31	0	0	0	0	0	0	0	76.68	0	0	12
2015	7	22	20	46	52	30	0	0	0	0	0	0	0	76.57	0	0	12
2015	7	22	20	56	52	30	0	0	0	0	0	0	0	76.48	0	0	12
2015	7	22	21	6	52	30	0	0	0	0	0	0	0	76.37	0	0	12
2015	7	22	21	16	52	30	0	0	0	0	0	0	0	76.28	0	0	12
2015	7	22	21	26	52	30	0	0	0	0	0	0	0	76.17	0	0	12
2015	7	22	21	36	52	31	0	0	0	0	0	0	0	76.08	0	0	12
2015	7	22	21	46	52	31	0	0	0	0	0	0	0	75.96	0	0	12
2015	7	22	21	56	52	30	0	0	0	0	0	0	0	75.85	0	0	12
2015	7	22	22	6	52	30	0	0	0	0	0	0	0	75.74	0	0	12
2015	7	22	22	16	52	30	0	0	0	0	0	0	0	75.61	0	0	12
2015	7	22	22	26	52	30	0	0	0	0	0	0	0	75.51	0	0	12
2015	7	22	22	36	52	30	0	0	0	0	0	0	0	75.38	0	0	12
2015	7	22	22	46	52	30	0	0	0	0	0	0	0	75.25	0	0	12
2015	7	22	22	56	52	31	0	0	0	0	0	0	0	75.15	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	22	23	6	52	30	0	0	0	0	0	0	0	75.02	0	0	12
2015	7	22	23	16	52	30	0	0	0	0	0	0	0	74.91	0	0	12
2015	7	22	23	26	52	30	0	0	0	0	0	0	0	74.79	0	0	12
2015	7	22	23	36	52	30	0	0	0	0	0	0	0	74.68	0	0	12
2015	7	22	23	46	52	30	0	0	0	0	0	0	0	74.57	0	0	12
2015	7	22	23	56	52	31	0	0	0	0	0	0	0	74.44	0	0	12
2015	7	23	0	6	52	30	0	0	0	0	0	0	0	74.34	0	0	12
2015	7	23	0	16	52	30	0	0	0	0	0	0	0	74.23	0	0	12
2015	7	23	0	26	52	31	0	0	0	0	0	0	0	74.12	0	0	12
2015	7	23	0	36	52	30	0	0	0	0	0	0	0	74.01	0	0	12
2015	7	23	0	46	52	31	0	0	0	0	0	0	0	73.9	0	0	12
2015	7	23	0	56	52	31	0	0	0	0	0	0	0	73.78	0	0	12
2015	7	23	1	6	52	30	0	0	0	0	0	0	0	73.69	0	0	12
2015	7	23	1	16	52	30	0	0	0	0	0	0	0	73.58	0	0	12
2015	7	23	1	26	52	30	0	0	0	0	0	0	0	73.47	0	0	12
2015	7	23	1	36	52	31	0	0	0	0	0	0	0	73.36	0	0	12
2015	7	23	1	46	52	30	0	0	0	0	0	0	0	73.27	0	0	12
2015	7	23	1	56	52	31	0	0	0	0	0	0	0	73.17	0	0	12
2015	7	23	2	6	52	30	0	0	0	0	0	0	0	73.08	0	0	12
2015	7	23	2	16	52	30	0	0	0	0	0	0	0	72.99	0	0	12
2015	7	23	2	26	52	31	0	0	0	0	0	0	0	72.9	0	0	12
2015	7	23	2	36	52	31	0	0	0	0	0	0	0	72.82	0	0	12
2015	7	23	2	46	52	31	0	0	0	0	0	0	0	72.75	0	0	12
2015	7	23	2	56	52	30	0	0	0	0	0	0	0	72.68	0	0	12
2015	7	23	3	6	52	31	0	0	0	0	0	0	0	72.59	0	0	12
2015	7	23	3	16	52	31	0	0	0	0	0	0	0	72.5	0	0	12
2015	7	23	3	26	52	30	0	0	0	0	0	0	0	72.43	0	0	12
2015	7	23	3	36	52	31	0	0	0	0	0	0	0	72.36	0	0	12
2015	7	23	3	46	52	32	0	0	0	0	0	0	0	72.28	0	0	12
2015	7	23	3	56	52	32	0	0	0	0	0	0	0	72.18	0	0	12
2015	7	23	4	6	52	30	0	0	0	0	0	0	0	72.1	0	0	12
2015	7	23	4	16	52	31	0	0	0	0	0	0	0	72.03	0	0	12
2015	7	23	4	26	52	31	0	0	0	0	0	0	0	71.98	0	0	12
2015	7	23	4	36	52	30	0	0	0	0	0	0	0	71.91	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	23	4	46	52	31	0	0	0	0	0	0	0	71.82	0	0	12
2015	7	23	4	56	52	31	0	0	0	0	0	0	0	71.74	0	0	12
2015	7	23	5	6	52	31	0	0	0	0	0	0	0	71.65	0	0	12
2015	7	23	5	16	52	31	0	0	0	0	0	0	0	71.56	0	0	12
2015	7	23	5	26	52	32	0	0	0	0	0	0	0	71.49	0	0	12
2015	7	23	5	36	52	31	0	0	0	0	0	0	0	71.4	0	0	12
2015	7	23	5	46	52	30	0	0	0	0	0	0	0	71.33	0	0	12
2015	7	23	5	56	52	30	0	0	0	0	0	0	0	71.24	0	0	12
2015	7	23	6	6	52	31	0	0	0	0	0	0	0	71.17	0	0	12
2015	7	23	6	16	52	31	0	0	0	0	0	0	0	71.11	0	0	12
2015	7	23	6	26	52	31	0	0	0	0	0	0	0	71.04	0	0	12
2015	7	23	6	36	52	30	0	0	0	0	0	0	0	71.01	0	0	12
2015	7	23	6	46	52	31	0	0	0	0	0	0	0	70.95	0	0	12
2015	7	23	6	56	52	30	0	0	0	0	0	0	0	70.97	0	0	12
2015	7	23	7	6	52	31	0	0	0	0	0	0	0	71.08	0	0	12.2
2015	7	23	7	16	52	30	0	0	0	0	0	0	0	71.13	0	0	12.4
2015	7	23	7	26	52	31	0	0	0	0	0	0	0	71.19	0	0	12.4
2015	7	23	7	36	52	31	0	0	0	0	0	0	0	71.26	0	0	12.6
2015	7	23	7	46	52	31	0	0	0	0	0	0	0	71.33	0	0	12.8
2015	7	23	7	56	52	31	0	0	0	0	0	0	0	71.4	0	0	12.8
2015	7	23	8	6	52	31	0	0	0	0	0	0	0	71.51	0	0	13
2015	7	23	8	16	52	31	0	0	0	0	0	0	0	71.64	0	0	13
2015	7	23	8	26	52	31	0	0	0	0	0	0	0	71.74	0	0	13
2015	7	23	8	36	52	31	0	0	0	0	0	0	0	71.83	0	0	13
2015	7	23	8	46	52	31	0	0	0	0	0	0	0	71.94	0	0	13
2015	7	23	8	56	52	31	0	0	0	0	0	0	0	72.05	0	0	13
2015	7	23	9	6	52	31	0	0	0	0	0	0	0	72.14	0	0	13.2
2015	7	23	9	16	52	30	0	0	0	0	0	0	0	72.25	0	0	13.2
2015	7	23	9	26	52	31	0	0	0	0	0	0	0	72.07	0	0	13.2
2015	7	23	9	36	52	30	0	0	0	0	0	0	0	72.3	0	0	13.2
2015	7	23	9	46	52	31	0	0	0	0	0	0	0	72.45	0	0	13.2
2015	7	23	9	56	52	31	0	0	0	0	0	0	0	72.59	0	0	13.2
2015	7	23	10	6	52	30	0	0	0	0	0	0	0	72.72	0	0	13.2
2015	7	23	10	16	52	30	0	0	0	0	0	0	0	72.81	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	23	10	26	52	31	0	0	0	0	0	0	0	72.95	0	0	13.2
2015	7	23	10	36	52	31	0	0	0	0	0	0	0	73.08	0	0	13.2
2015	7	23	10	46	52	30	0	0	0	0	0	0	0	73.24	0	0	13.2
2015	7	23	10	56	52	31	0	0	0	0	0	0	0	73.36	0	0	13.2
2015	7	23	11	6	52	31	0	0	0	0	0	0	0	73.51	0	0	13.2
2015	7	23	11	16	52	31	0	0	0	0	0	0	0	73.69	0	0	13.2
2015	7	23	11	26	52	30	0	0	0	0	0	0	0	73.87	0	0	13.2
2015	7	23	11	36	52	31	0	0	0	0	0	0	0	74.03	0	0	13.2
2015	7	23	11	46	52	31	0	0	0	0	0	0	0	73.33	0	0	13.2
2015	7	23	11	56	52	32	0	0	0	0	0	0	0	73.2	0	0	13.2
2015	7	23	12	6	52	31	0	0	0	0	0	0	0	73.31	0	0	13.2
2015	7	23	12	16	52	31	0	0	0	0	0	0	0	73.47	0	0	13.2
2015	7	23	12	26	52	30	0	0	0	0	0	0	0	73.69	0	0	13.2
2015	7	23	12	36	52	31	0	0	0	0	0	0	0	73.9	0	0	13.2
2015	7	23	12	46	52	30	0	0	0	0	0	0	0	74.17	0	0	13.2
2015	7	23	12	56	52	31	0	0	0	0	0	0	0	74.44	0	0	13.2
2015	7	23	13	6	52	30	0	0	0	0	0	0	0	75.16	0	0	13.2
2015	7	23	13	16	52	30	0	0	0	0	0	0	0	75.88	0	0	13.2
2015	7	23	13	26	52	30	0	0	0	0	0	0	0	76.24	0	0	13.2
2015	7	23	13	36	52	30	0	0	0	0	0	0	0	76.53	0	0	13.2
2015	7	23	13	46	52	31	0	0	0	0	0	0	0	76.75	0	0	13.2
2015	7	23	13	56	52	30	0	0	0	0	0	0	0	76.91	0	0	13.2
2015	7	23	14	6	52	30	0	0	0	0	0	0	0	77.2	0	0	13.2
2015	7	23	14	16	52	30	0	0	0	0	0	0	0	77.43	0	0	13.2
2015	7	23	14	26	52	30	0	0	0	0	0	0	0	77.05	0	0	13
2015	7	23	14	36	52	30	0	0	0	0	0	0	0	77.49	0	0	13
2015	7	23	14	46	52	30	0	0	0	0	0	0	0	77.68	0	0	13.2
2015	7	23	14	56	52	30	0	0	0	0	0	0	0	77.99	0	0	13.2
2015	7	23	15	6	52	30	0	0	0	0	0	0	0	77.83	0	0	13
2015	7	23	15	16	52	31	0	0	0	0	0	0	0	77.67	0	0	12.6
2015	7	23	15	26	52	30	0	0	0	0	0	0	0	77.97	0	0	12.8
2015	7	23	15	36	52	30	0	0	0	0	0	0	0	77.95	0	0	12.8
2015	7	23	15	46	52	30	0	0	0	0	0	0	0	77.79	0	0	12.6
2015	7	23	15	56	52	30	0	0	0	0	0	0	0	77.94	0	0	12.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	23	16	6	52	30	0	0	0	0	0	0	0	78.19	0	0	13
2015	7	23	16	16	52	30	0	0	0	0	0	0	0	78.3	0	0	13
2015	7	23	16	26	52	30	0	0	0	0	0	0	0	78.15	0	0	12.6
2015	7	23	16	36	52	31	0	0	0	0	0	0	0	78.24	0	0	12.6
2015	7	23	16	46	52	30	0	0	0	0	0	0	0	78.31	0	0	12.6
2015	7	23	16	56	52	30	0	0	0	0	0	0	0	78.37	0	0	12.6
2015	7	23	17	6	52	29	0	0	0	0	0	0	0	78.39	0	0	12.4
2015	7	23	17	16	52	30	0	0	0	0	0	0	0	78.4	0	0	12.4
2015	7	23	17	26	52	29	0	0	0	0	0	0	0	78.4	0	0	12.4
2015	7	23	17	36	52	30	0	0	0	0	0	0	0	78.28	0	0	12.2
2015	7	23	17	46	52	30	0	0	0	0	0	0	0	78.21	0	0	12.2
2015	7	23	17	56	52	30	0	0	0	0	0	0	0	78.17	0	0	12.2
2015	7	23	18	6	52	30	0	0	0	0	0	0	0	78.15	0	0	12.2
2015	7	23	18	16	52	30	0	0	0	0	0	0	0	78.13	0	0	12.2
2015	7	23	18	26	52	30	0	0	0	0	0	0	0	78.12	0	0	12.2
2015	7	23	18	36	52	31	0	0	0	0	0	0	0	78.1	0	0	12.2
2015	7	23	18	46	52	30	0	0	0	0	0	0	0	78.06	0	0	12.2
2015	7	23	18	56	52	31	0	0	0	0	0	0	0	78.03	0	0	12.2
2015	7	23	19	6	52	30	0	0	0	0	0	0	0	77.99	0	0	12.2
2015	7	23	19	16	52	30	0	0	0	0	0	0	0	77.94	0	0	12.2
2015	7	23	19	26	52	30	0	0	0	0	0	0	0	77.86	0	0	12.2
2015	7	23	19	36	52	30	0	0	0	0	0	0	0	77.79	0	0	12.2
2015	7	23	19	46	52	31	0	0	0	0	0	0	0	77.7	0	0	12.2
2015	7	23	19	56	52	30	0	0	0	0	0	0	0	77.63	0	0	12.2
2015	7	23	20	6	52	30	0	0	0	0	0	0	0	77.54	0	0	12.2
2015	7	23	20	16	52	31	0	0	0	0	0	0	0	77.47	0	0	12.2
2015	7	23	20	26	52	30	0	0	0	0	0	0	0	77.4	0	0	12.2
2015	7	23	20	36	52	30	0	0	0	0	0	0	0	77.32	0	0	12.2
2015	7	23	20	46	52	31	0	0	0	0	0	0	0	77.23	0	0	12.2
2015	7	23	20	56	52	30	0	0	0	0	0	0	0	77.16	0	0	12
2015	7	23	21	6	52	30	0	0	0	0	0	0	0	77.07	0	0	12
2015	7	23	21	16	52	30	0	0	0	0	0	0	0	76.98	0	0	12
2015	7	23	21	26	52	31	0	0	0	0	0	0	0	76.87	0	0	12
2015	7	23	21	36	52	30	0	0	0	0	0	0	0	76.78	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	23	21	46	52	30	0	0	0	0	0	0	0	76.66	0	0	12
2015	7	23	21	56	52	30	0	0	0	0	0	0	0	76.55	0	0	12
2015	7	23	22	6	52	31	0	0	0	0	0	0	0	76.42	0	0	12
2015	7	23	22	16	52	30	0	0	0	0	0	0	0	76.3	0	0	12
2015	7	23	22	26	52	30	0	0	0	0	0	0	0	76.15	0	0	12
2015	7	23	22	36	52	31	0	0	0	0	0	0	0	76.01	0	0	12
2015	7	23	22	46	52	30	0	0	0	0	0	0	0	75.87	0	0	12
2015	7	23	22	56	52	31	0	0	0	0	0	0	0	75.72	0	0	12
2015	7	23	23	6	52	30	0	0	0	0	0	0	0	75.56	0	0	12
2015	7	23	23	16	52	31	0	0	0	0	0	0	0	75.42	0	0	12
2015	7	23	23	26	52	30	0	0	0	0	0	0	0	75.27	0	0	12
2015	7	23	23	36	52	30	0	0	0	0	0	0	0	75.13	0	0	12
2015	7	23	23	46	52	30	0	0	0	0	0	0	0	74.97	0	0	12
2015	7	23	23	56	52	31	0	0	0	0	0	0	0	74.82	0	0	12
2015	7	24	0	6	52	31	0	0	0	0	0	0	0	74.66	0	0	12
2015	7	24	0	16	52	30	0	0	0	0	0	0	0	74.52	0	0	12
2015	7	24	0	26	52	30	0	0	0	0	0	0	0	74.39	0	0	12
2015	7	24	0	36	52	31	0	0	0	0	0	0	0	74.26	0	0	12
2015	7	24	0	46	52	31	0	0	0	0	0	0	0	74.12	0	0	12
2015	7	24	0	56	52	31	0	0	0	0	0	0	0	73.99	0	0	12
2015	7	24	1	6	52	31	0	0	0	0	0	0	0	73.83	0	0	12
2015	7	24	1	16	52	30	0	0	0	0	0	0	0	73.71	0	0	12
2015	7	24	1	26	52	30	0	0	0	0	0	0	0	73.58	0	0	12
2015	7	24	1	36	52	30	0	0	0	0	0	0	0	73.47	0	0	12
2015	7	24	1	46	52	30	0	0	0	0	0	0	0	73.35	0	0	12
2015	7	24	1	56	52	31	0	0	0	0	0	0	0	73.22	0	0	12
2015	7	24	2	6	52	30	0	0	0	0	0	0	0	73.11	0	0	12
2015	7	24	2	16	52	31	0	0	0	0	0	0	0	73	0	0	12
2015	7	24	2	26	52	31	0	0	0	0	0	0	0	72.9	0	0	12
2015	7	24	2	36	52	31	0	0	0	0	0	0	0	72.79	0	0	12
2015	7	24	2	46	52	30	0	0	0	0	0	0	0	72.7	0	0	12
2015	7	24	2	56	52	31	0	0	0	0	0	0	0	72.61	0	0	12
2015	7	24	3	6	52	30	0	0	0	0	0	0	0	72.52	0	0	12
2015	7	24	3	16	52	31	0	0	0	0	0	0	0	72.45	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	24	3	26	52	31	0	0	0	0	0	0	0	72.34	0	0	12
2015	7	24	3	36	52	30	0	0	0	0	0	0	0	72.25	0	0	12
2015	7	24	3	46	52	30	0	0	0	0	0	0	0	72.14	0	0	12
2015	7	24	3	56	52	31	0	0	0	0	0	0	0	72.03	0	0	12
2015	7	24	4	6	52	30	0	0	0	0	0	0	0	71.92	0	0	12
2015	7	24	4	16	52	30	0	0	0	0	0	0	0	71.82	0	0	12
2015	7	24	4	26	52	30	0	0	0	0	0	0	0	71.71	0	0	12
2015	7	24	4	36	52	31	0	0	0	0	0	0	0	71.6	0	0	12
2015	7	24	4	46	52	31	0	0	0	0	0	0	0	71.47	0	0	12
2015	7	24	4	56	52	31	0	0	0	0	0	0	0	71.37	0	0	12
2015	7	24	5	6	52	31	0	0	0	0	0	0	0	71.26	0	0	12
2015	7	24	5	16	52	31	0	0	0	0	0	0	0	71.15	0	0	12
2015	7	24	5	26	52	31	0	0	0	0	0	0	0	71.06	0	0	12
2015	7	24	5	36	52	31	0	0	0	0	0	0	0	70.97	0	0	12
2015	7	24	5	46	52	31	0	0	0	0	0	0	0	70.86	0	0	12
2015	7	24	5	56	52	31	0	0	0	0	0	0	0	70.77	0	0	12
2015	7	24	6	6	52	31	0	0	0	0	0	0	0	70.66	0	0	12
2015	7	24	6	16	52	31	0	0	0	0	0	0	0	70.57	0	0	12
2015	7	24	6	26	52	31	0	0	0	0	0	0	0	70.47	0	0	12
2015	7	24	6	36	52	31	0	0	0	0	0	0	0	70.36	0	0	12
2015	7	24	6	46	52	31	0	0	0	0	0	0	0	70.27	0	0	12
2015	7	24	6	56	52	31	0	0	0	0	0	0	0	70.23	0	0	12
2015	7	24	7	6	52	32	0	0	0	0	0	0	0	70.32	0	0	12.2
2015	7	24	7	16	52	32	0	0	0	0	0	0	0	70.34	0	0	12.4
2015	7	24	7	26	52	30	0	0	0	0	0	0	0	70.39	0	0	12.6
2015	7	24	7	36	52	31	0	0	0	0	0	0	0	70.45	0	0	12.6
2015	7	24	7	46	52	31	0	0	0	0	0	0	0	70.52	0	0	12.8
2015	7	24	7	56	52	30	0	0	0	0	0	0	0	70.57	0	0	12.8
2015	7	24	8	6	52	31	0	0	0	0	0	0	0	70.68	0	0	13
2015	7	24	8	16	52	31	0	0	0	0	0	0	0	70.79	0	0	13
2015	7	24	8	26	52	31	0	0	0	0	0	0	0	70.9	0	0	13
2015	7	24	8	36	52	31	0	0	0	0	0	0	0	70.97	0	0	13
2015	7	24	8	46	52	31	0	0	0	0	0	0	0	71.06	0	0	13
2015	7	24	8	56	52	31	0	0	0	0	0	0	0	71.19	0	0	13

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	24	9	6	52	31	0	0	0	0	0	0	0	71.31	0	0	13.2
2015	7	24	9	16	52	32	0	0	0	0	0	0	0	71.44	0	0	13.2
2015	7	24	9	26	52	31	0	0	0	0	0	0	0	71.58	0	0	13.2
2015	7	24	9	36	52	31	0	0	0	0	0	0	0	71.73	0	0	13.2
2015	7	24	9	46	52	31	0	0	0	0	0	0	0	71.83	0	0	13.2
2015	7	24	9	56	52	31	0	0	0	0	0	0	0	71.98	0	0	13.2
2015	7	24	10	6	52	31	0	0	0	0	0	0	0	72.12	0	0	13.2
2015	7	24	10	16	52	31	0	0	0	0	0	0	0	72.27	0	0	13.2
2015	7	24	10	26	52	32	0	0	0	0	0	0	0	72.43	0	0	13.2
2015	7	24	10	36	52	31	0	0	0	0	0	0	0	72.55	0	0	13.2
2015	7	24	10	46	52	31	0	0	0	0	0	0	0	72.68	0	0	13.2
2015	7	24	10	56	52	31	0	0	0	0	0	0	0	72.9	0	0	13.2
2015	7	24	11	6	52	31	0	0	0	0	0	0	0	73.06	0	0	13.2
2015	7	24	11	16	52	31	0	0	0	0	0	0	0	73.22	0	0	13.2
2015	7	24	11	26	52	31	0	0	0	0	0	0	0	73.4	0	0	13.2
2015	7	24	11	36	52	31	0	0	0	0	0	0	0	73.56	0	0	13.2
2015	7	24	11	46	52	31	0	0	0	0	0	0	0	72.75	0	0	13.2
2015	7	24	11	56	52	31	0	0	0	0	0	0	0	72.68	0	0	13.2
2015	7	24	12	6	52	31	0	0	0	0	0	0	0	72.81	0	0	13.4
2015	7	24	12	16	52	31	0	0	0	0	0	0	0	73.02	0	0	13.4
2015	7	24	12	26	52	30	0	0	0	0	0	0	0	73.24	0	0	13.4
2015	7	24	12	36	52	30	0	0	0	0	0	0	0	73.47	0	0	13.4
2015	7	24	12	46	52	30	0	0	0	0	0	0	0	73.72	0	0	13.4
2015	7	24	12	56	52	31	0	0	0	0	0	0	0	74.03	0	0	13.4
2015	7	24	13	6	52	30	0	0	0	0	0	0	0	74.98	0	0	13.4
2015	7	24	13	16	52	30	0	0	0	0	0	0	0	75.63	0	0	13.4
2015	7	24	13	26	52	30	0	0	0	0	0	0	0	75.99	0	0	13.4
2015	7	24	13	36	52	30	0	0	0	0	0	0	0	76.32	0	0	13.4
2015	7	24	13	46	52	30	0	0	0	0	0	0	0	76.53	0	0	13.4
2015	7	24	13	56	52	30	0	0	0	0	0	0	0	76.77	0	0	13.2
2015	7	24	14	6	52	30	0	0	0	0	0	0	0	77.02	0	0	13.2
2015	7	24	14	16	52	30	0	0	0	0	0	0	0	77.18	0	0	13.2
2015	7	24	14	26	52	30	0	0	0	0	0	0	0	77.41	0	0	13.2
2015	7	24	14	36	52	30	0	0	0	0	0	0	0	77.58	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	24	14	46	52	30	0	0	0	0	0	0	0	77.76	0	0	13.2
2015	7	24	14	56	52	30	0	0	0	0	0	0	0	77.9	0	0	13.2
2015	7	24	15	6	52	30	0	0	0	0	0	0	0	78.04	0	0	13.2
2015	7	24	15	16	52	30	0	0	0	0	0	0	0	78.21	0	0	13.2
2015	7	24	15	26	52	30	0	0	0	0	0	0	0	78.33	0	0	13.2
2015	7	24	15	36	52	30	0	0	0	0	0	0	0	78.46	0	0	13.2
2015	7	24	15	46	52	30	0	0	0	0	0	0	0	78.58	0	0	13
2015	7	24	15	56	52	30	0	0	0	0	0	0	0	78.67	0	0	13
2015	7	24	16	6	52	29	0	0	0	0	0	0	0	78.78	0	0	13
2015	7	24	16	16	52	29	0	0	0	0	0	0	0	78.8	0	0	12.8
2015	7	24	16	26	52	30	0	0	0	0	0	0	0	78.82	0	0	12.8
2015	7	24	16	36	52	30	0	0	0	0	0	0	0	78.91	0	0	12.6
2015	7	24	16	46	52	30	0	0	0	0	0	0	0	78.93	0	0	12.6
2015	7	24	16	56	52	30	0	0	0	0	0	0	0	78.98	0	0	12.4
2015	7	24	17	6	52	30	0	0	0	0	0	0	0	79	0	0	12.4
2015	7	24	17	16	52	29	0	0	0	0	0	0	0	79.05	0	0	12.4
2015	7	24	17	26	52	31	0	0	0	0	0	0	0	79.05	0	0	12.2
2015	7	24	17	36	52	30	0	0	0	0	0	0	0	78.89	0	0	12.2
2015	7	24	17	46	52	30	0	0	0	0	0	0	0	78.8	0	0	12.2
2015	7	24	17	56	52	30	0	0	0	0	0	0	0	78.78	0	0	12.2
2015	7	24	18	6	52	30	0	0	0	0	0	0	0	78.78	0	0	12.2
2015	7	24	18	16	52	30	0	0	0	0	0	0	0	78.8	0	0	12.2
2015	7	24	18	26	52	31	0	0	0	0	0	0	0	78.8	0	0	12.2
2015	7	24	18	36	52	30	0	0	0	0	0	0	0	78.8	0	0	12.2
2015	7	24	18	46	52	30	0	0	0	0	0	0	0	78.78	0	0	12.2
2015	7	24	18	56	52	30	0	0	0	0	0	0	0	78.76	0	0	12.2
2015	7	24	19	6	52	30	0	0	0	0	0	0	0	78.73	0	0	12.2
2015	7	24	19	16	52	30	0	0	0	0	0	0	0	78.69	0	0	12.2
2015	7	24	19	26	52	31	0	0	0	0	0	0	0	78.64	0	0	12.2
2015	7	24	19	36	52	30	0	0	0	0	0	0	0	78.57	0	0	12.2
2015	7	24	19	46	52	30	0	0	0	0	0	0	0	78.49	0	0	12.2
2015	7	24	19	56	52	30	0	0	0	0	0	0	0	78.42	0	0	12.2
2015	7	24	20	6	52	30	0	0	0	0	0	0	0	78.35	0	0	12.2
2015	7	24	20	16	52	30	0	0	0	0	0	0	0	78.28	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	24	20	26	52	30	0	0	0	0	0	0	0	78.19	0	0	12.2
2015	7	24	20	36	52	30	0	0	0	0	0	0	0	78.1	0	0	12.2
2015	7	24	20	46	52	30	0	0	0	0	0	0	0	77.99	0	0	12
2015	7	24	20	56	52	30	0	0	0	0	0	0	0	77.88	0	0	12
2015	7	24	21	6	52	30	0	0	0	0	0	0	0	77.77	0	0	12
2015	7	24	21	16	52	30	0	0	0	0	0	0	0	77.65	0	0	12
2015	7	24	21	26	52	30	0	0	0	0	0	0	0	77.54	0	0	12
2015	7	24	21	36	52	30	0	0	0	0	0	0	0	77.41	0	0	12
2015	7	24	21	46	52	31	0	0	0	0	0	0	0	77.27	0	0	12
2015	7	24	21	56	52	30	0	0	0	0	0	0	0	77.13	0	0	12
2015	7	24	22	6	52	30	0	0	0	0	0	0	0	77	0	0	12
2015	7	24	22	16	52	30	0	0	0	0	0	0	0	76.86	0	0	12
2015	7	24	22	26	52	31	0	0	0	0	0	0	0	76.71	0	0	12
2015	7	24	22	36	52	30	0	0	0	0	0	0	0	76.55	0	0	12
2015	7	24	22	46	52	30	0	0	0	0	0	0	0	76.41	0	0	12
2015	7	24	22	56	52	30	0	0	0	0	0	0	0	76.26	0	0	12
2015	7	24	23	6	52	30	0	0	0	0	0	0	0	76.1	0	0	12
2015	7	24	23	16	52	31	0	0	0	0	0	0	0	75.96	0	0	12
2015	7	24	23	26	52	30	0	0	0	0	0	0	0	75.81	0	0	12
2015	7	24	23	36	52	31	0	0	0	0	0	0	0	75.67	0	0	12
2015	7	24	23	46	52	30	0	0	0	0	0	0	0	75.52	0	0	12
2015	7	24	23	56	52	30	0	0	0	0	0	0	0	75.4	0	0	12
2015	7	25	0	6	52	30	0	0	0	0	0	0	0	75.25	0	0	12
2015	7	25	0	16	52	30	0	0	0	0	0	0	0	75.13	0	0	12
2015	7	25	0	26	52	30	0	0	0	0	0	0	0	75	0	0	12
2015	7	25	0	36	52	31	0	0	0	0	0	0	0	74.88	0	0	12
2015	7	25	0	46	52	31	0	0	0	0	0	0	0	74.77	0	0	12
2015	7	25	0	56	52	30	0	0	0	0	0	0	0	74.64	0	0	12
2015	7	25	1	6	52	31	0	0	0	0	0	0	0	74.55	0	0	12
2015	7	25	1	16	52	30	0	0	0	0	0	0	0	74.44	0	0	12
2015	7	25	1	26	52	31	0	0	0	0	0	0	0	74.35	0	0	12
2015	7	25	1	36	52	30	0	0	0	0	0	0	0	74.25	0	0	12
2015	7	25	1	46	52	30	0	0	0	0	0	0	0	74.14	0	0	12
2015	7	25	1	56	52	31	0	0	0	0	0	0	0	74.05	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	25	2	6	52	30	0	0	0	0	0	0	0	73.94	0	0	12
2015	7	25	2	16	52	30	0	0	0	0	0	0	0	73.83	0	0	12
2015	7	25	2	26	52	31	0	0	0	0	0	0	0	73.71	0	0	12
2015	7	25	2	36	52	30	0	0	0	0	0	0	0	73.58	0	0	12
2015	7	25	2	46	52	31	0	0	0	0	0	0	0	73.47	0	0	12
2015	7	25	2	56	52	30	0	0	0	0	0	0	0	73.35	0	0	12
2015	7	25	3	6	52	30	0	0	0	0	0	0	0	73.22	0	0	12
2015	7	25	3	16	52	30	0	0	0	0	0	0	0	73.09	0	0	12
2015	7	25	3	26	52	30	0	0	0	0	0	0	0	72.97	0	0	12
2015	7	25	3	36	52	31	0	0	0	0	0	0	0	72.86	0	0	12
2015	7	25	3	46	52	30	0	0	0	0	0	0	0	72.72	0	0	12
2015	7	25	3	56	52	30	0	0	0	0	0	0	0	72.61	0	0	12
2015	7	25	4	6	52	31	0	0	0	0	0	0	0	72.48	0	0	12
2015	7	25	4	16	52	31	0	0	0	0	0	0	0	72.36	0	0	12
2015	7	25	4	26	52	31	0	0	0	0	0	0	0	72.25	0	0	12
2015	7	25	4	36	52	30	0	0	0	0	0	0	0	72.14	0	0	12
2015	7	25	4	46	52	31	0	0	0	0	0	0	0	72.03	0	0	12
2015	7	25	4	56	52	30	0	0	0	0	0	0	0	71.94	0	0	12
2015	7	25	5	6	52	30	0	0	0	0	0	0	0	71.83	0	0	12
2015	7	25	5	16	52	32	0	0	0	0	0	0	0	71.74	0	0	12
2015	7	25	5	26	52	31	0	0	0	0	0	0	0	71.65	0	0	12
2015	7	25	5	36	52	30	0	0	0	0	0	0	0	71.55	0	0	12
2015	7	25	5	46	52	31	0	0	0	0	0	0	0	71.47	0	0	12
2015	7	25	5	56	52	31	0	0	0	0	0	0	0	71.38	0	0	12
2015	7	25	6	6	52	31	0	0	0	0	0	0	0	71.29	0	0	12
2015	7	25	6	16	52	31	0	0	0	0	0	0	0	71.22	0	0	12
2015	7	25	6	26	52	31	0	0	0	0	0	0	0	71.15	0	0	12
2015	7	25	6	36	52	31	0	0	0	0	0	0	0	71.08	0	0	12
2015	7	25	6	46	52	31	0	0	0	0	0	0	0	71.01	0	0	12
2015	7	25	6	56	52	31	0	0	0	0	0	0	0	70.97	0	0	12
2015	7	25	7	6	52	31	0	0	0	0	0	0	0	71.08	0	0	12.2
2015	7	25	7	16	52	31	0	0	0	0	0	0	0	71.08	0	0	12.4
2015	7	25	7	26	52	31	0	0	0	0	0	0	0	71.1	0	0	12.6
2015	7	25	7	36	52	31	0	0	0	0	0	0	0	71.13	0	0	12.6

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	25	7	46	52	30	0	0	0	0	0	0	0	71.13	0	0	12.8
2015	7	25	7	56	52	32	0	0	0	0	0	0	0	71.13	0	0	12.8
2015	7	25	8	6	52	30	0	0	0	0	0	0	0	71.26	0	0	13
2015	7	25	8	16	52	31	0	0	0	0	0	0	0	71.33	0	0	13
2015	7	25	8	26	52	30	0	0	0	0	0	0	0	71.38	0	0	13.2
2015	7	25	8	36	52	31	0	0	0	0	0	0	0	71.46	0	0	13.2
2015	7	25	8	46	52	30	0	0	0	0	0	0	0	71.53	0	0	13.2
2015	7	25	8	56	52	31	0	0	0	0	0	0	0	71.64	0	0	13.2
2015	7	25	9	6	52	31	0	0	0	0	0	0	0	71.71	0	0	13.4
2015	7	25	9	16	52	31	0	0	0	0	0	0	0	71.8	0	0	13.4
2015	7	25	9	26	52	31	0	0	0	0	0	0	0	71.87	0	0	13.4
2015	7	25	9	36	52	30	0	0	0	0	0	0	0	71.94	0	0	13.2
2015	7	25	9	46	52	30	0	0	0	0	0	0	0	72.09	0	0	13.2
2015	7	25	9	56	52	31	0	0	0	0	0	0	0	72.21	0	0	13.2
2015	7	25	10	6	52	30	0	0	0	0	0	0	0	72.37	0	0	13.2
2015	7	25	10	16	52	30	0	0	0	0	0	0	0	72.45	0	0	13.2
2015	7	25	10	26	52	31	0	0	0	0	0	0	0	72.63	0	0	13.2
2015	7	25	10	36	52	30	0	0	0	0	0	0	0	72.72	0	0	13.2
2015	7	25	10	46	52	31	0	0	0	0	0	0	0	72.84	0	0	13.2
2015	7	25	10	56	52	31	0	0	0	0	0	0	0	73.02	0	0	13.2
2015	7	25	11	6	52	30	0	0	0	0	0	0	0	73.18	0	0	13.2
2015	7	25	11	16	52	31	0	0	0	0	0	0	0	73.35	0	0	13.2
2015	7	25	11	26	52	30	0	0	0	0	0	0	0	73.54	0	0	13.2
2015	7	25	11	36	52	31	0	0	0	0	0	0	0	73.65	0	0	13.2
2015	7	25	11	46	52	31	0	0	0	0	0	0	0	72.93	0	0	13.2
2015	7	25	11	56	52	31	0	0	0	0	0	0	0	72.9	0	0	13.2
2015	7	25	12	6	52	31	0	0	0	0	0	0	0	73.02	0	0	13.2
2015	7	25	12	16	52	31	0	0	0	0	0	0	0	73.2	0	0	13.2
2015	7	25	12	26	52	31	0	0	0	0	0	0	0	73.4	0	0	13.2
2015	7	25	12	36	52	31	0	0	0	0	0	0	0	73.62	0	0	13.2
2015	7	25	12	46	52	30	0	0	0	0	0	0	0	73.83	0	0	13.2
2015	7	25	12	56	52	30	0	0	0	0	0	0	0	74.1	0	0	13.2
2015	7	25	13	6	52	31	0	0	0	0	0	0	0	75.04	0	0	13.2
2015	7	25	13	16	52	31	0	0	0	0	0	0	0	75.54	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	25	13	26	52	30	0	0	0	0	0	0	0	75.79	0	0	13.2
2015	7	25	13	36	52	30	0	0	0	0	0	0	0	76.05	0	0	13.2
2015	7	25	13	46	52	30	0	0	0	0	0	0	0	76.24	0	0	13.2
2015	7	25	13	56	52	31	0	0	0	0	0	0	0	76.44	0	0	13.2
2015	7	25	14	6	52	30	0	0	0	0	0	0	0	76.62	0	0	13.2
2015	7	25	14	16	52	30	0	0	0	0	0	0	0	76.82	0	0	13.2
2015	7	25	14	26	52	31	0	0	0	0	0	0	0	77.04	0	0	13.2
2015	7	25	14	36	52	30	0	0	0	0	0	0	0	77.16	0	0	13.2
2015	7	25	14	46	52	30	0	0	0	0	0	0	0	77.34	0	0	13.2
2015	7	25	14	56	52	31	0	0	0	0	0	0	0	77.49	0	0	13.2
2015	7	25	15	6	52	30	0	0	0	0	0	0	0	77.65	0	0	13.2
2015	7	25	15	16	52	31	0	0	0	0	0	0	0	77.76	0	0	13.2
2015	7	25	15	26	52	30	0	0	0	0	0	0	0	77.86	0	0	13.2
2015	7	25	15	36	52	30	0	0	0	0	0	0	0	78.01	0	0	13.2
2015	7	25	15	46	52	30	0	0	0	0	0	0	0	78.1	0	0	13
2015	7	25	15	56	52	30	0	0	0	0	0	0	0	78.17	0	0	13
2015	7	25	16	6	52	30	0	0	0	0	0	0	0	78.24	0	0	13
2015	7	25	16	16	52	31	0	0	0	0	0	0	0	78.24	0	0	12.8
2015	7	25	16	26	52	30	0	0	0	0	0	0	0	78.3	0	0	12.8
2015	7	25	16	36	52	30	0	0	0	0	0	0	0	78.31	0	0	12.6
2015	7	25	16	46	52	31	0	0	0	0	0	0	0	78.37	0	0	12.6
2015	7	25	16	56	52	30	0	0	0	0	0	0	0	78.4	0	0	12.4
2015	7	25	17	6	52	30	0	0	0	0	0	0	0	78.44	0	0	12.4
2015	7	25	17	16	52	30	0	0	0	0	0	0	0	78.48	0	0	12.4
2015	7	25	17	26	52	30	0	0	0	0	0	0	0	78.48	0	0	12.2
2015	7	25	17	36	52	29	0	0	0	0	0	0	0	78.33	0	0	12.2
2015	7	25	17	46	52	30	0	0	0	0	0	0	0	78.24	0	0	12.2
2015	7	25	17	56	52	30	0	0	0	0	0	0	0	78.24	0	0	12.2
2015	7	25	18	6	52	30	0	0	0	0	0	0	0	78.22	0	0	12.2
2015	7	25	18	16	52	30	0	0	0	0	0	0	0	78.22	0	0	12.2
2015	7	25	18	26	52	30	0	0	0	0	0	0	0	78.22	0	0	12.2
2015	7	25	18	36	52	30	0	0	0	0	0	0	0	78.22	0	0	12.2
2015	7	25	18	46	52	30	0	0	0	0	0	0	0	78.21	0	0	12.2
2015	7	25	18	56	52	30	0	0	0	0	0	0	0	78.19	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	25	19	6	52	30	0	0	0	0	0	0	0	78.17	0	0	12.2
2015	7	25	19	16	52	30	0	0	0	0	0	0	0	78.13	0	0	12.2
2015	7	25	19	26	52	29	0	0	0	0	0	0	0	78.1	0	0	12.2
2015	7	25	19	36	52	30	0	0	0	0	0	0	0	78.03	0	0	12.2
2015	7	25	19	46	52	30	0	0	0	0	0	0	0	77.99	0	0	12.2
2015	7	25	19	56	52	30	0	0	0	0	0	0	0	77.92	0	0	12.2
2015	7	25	20	6	52	30	0	0	0	0	0	0	0	77.85	0	0	12.2
2015	7	25	20	16	52	30	0	0	0	0	0	0	0	77.76	0	0	12.2
2015	7	25	20	26	52	30	0	0	0	0	0	0	0	77.68	0	0	12.2
2015	7	25	20	36	52	30	0	0	0	0	0	0	0	77.58	0	0	12.2
2015	7	25	20	46	52	30	0	0	0	0	0	0	0	77.47	0	0	12.2
2015	7	25	20	56	52	30	0	0	0	0	0	0	0	77.34	0	0	12
2015	7	25	21	6	52	30	0	0	0	0	0	0	0	77.2	0	0	12
2015	7	25	21	16	52	30	0	0	0	0	0	0	0	77.05	0	0	12
2015	7	25	21	26	52	30	0	0	0	0	0	0	0	76.93	0	0	12
2015	7	25	21	36	52	30	0	0	0	0	0	0	0	76.78	0	0	12
2015	7	25	21	46	52	31	0	0	0	0	0	0	0	76.66	0	0	12
2015	7	25	21	56	52	30	0	0	0	0	0	0	0	76.51	0	0	12
2015	7	25	22	6	52	31	0	0	0	0	0	0	0	76.37	0	0	12
2015	7	25	22	16	52	30	0	0	0	0	0	0	0	76.24	0	0	12
2015	7	25	22	26	52	30	0	0	0	0	0	0	0	76.1	0	0	12
2015	7	25	22	36	52	30	0	0	0	0	0	0	0	75.96	0	0	12
2015	7	25	22	46	52	31	0	0	0	0	0	0	0	75.81	0	0	12
2015	7	25	22	56	52	30	0	0	0	0	0	0	0	75.67	0	0	12
2015	7	25	23	6	52	31	0	0	0	0	0	0	0	75.52	0	0	12
2015	7	25	23	16	52	30	0	0	0	0	0	0	0	75.36	0	0	12
2015	7	25	23	26	52	30	0	0	0	0	0	0	0	75.22	0	0	12
2015	7	25	23	36	52	31	0	0	0	0	0	0	0	75.07	0	0	12
2015	7	25	23	46	52	30	0	0	0	0	0	0	0	74.95	0	0	12
2015	7	25	23	56	52	30	0	0	0	0	0	0	0	74.8	0	0	12
2015	7	26	0	6	52	31	0	0	0	0	0	0	0	74.68	0	0	12
2015	7	26	0	16	52	30	0	0	0	0	0	0	0	74.55	0	0	12
2015	7	26	0	26	52	30	0	0	0	0	0	0	0	74.43	0	0	12
2015	7	26	0	36	52	30	0	0	0	0	0	0	0	74.3	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	26	0	46	52	31	0	0	0	0	0	0	0	74.17	0	0	12
2015	7	26	0	56	52	31	0	0	0	0	0	0	0	74.05	0	0	12
2015	7	26	1	6	52	31	0	0	0	0	0	0	0	73.92	0	0	12
2015	7	26	1	16	52	31	0	0	0	0	0	0	0	73.8	0	0	12
2015	7	26	1	26	52	31	0	0	0	0	0	0	0	73.65	0	0	12
2015	7	26	1	36	52	30	0	0	0	0	0	0	0	73.51	0	0	12
2015	7	26	1	46	52	30	0	0	0	0	0	0	0	73.36	0	0	12
2015	7	26	1	56	52	31	0	0	0	0	0	0	0	73.22	0	0	12
2015	7	26	2	6	52	31	0	0	0	0	0	0	0	73.09	0	0	12
2015	7	26	2	16	52	31	0	0	0	0	0	0	0	72.97	0	0	12
2015	7	26	2	26	52	31	0	0	0	0	0	0	0	72.84	0	0	12
2015	7	26	2	36	52	30	0	0	0	0	0	0	0	72.72	0	0	12
2015	7	26	2	46	52	31	0	0	0	0	0	0	0	72.59	0	0	12
2015	7	26	2	56	52	31	0	0	0	0	0	0	0	72.46	0	0	12
2015	7	26	3	6	52	31	0	0	0	0	0	0	0	72.32	0	0	12
2015	7	26	3	16	52	30	0	0	0	0	0	0	0	72.19	0	0	12
2015	7	26	3	26	52	30	0	0	0	0	0	0	0	72.05	0	0	12
2015	7	26	3	36	52	31	0	0	0	0	0	0	0	71.92	0	0	12
2015	7	26	3	46	52	31	0	0	0	0	0	0	0	71.78	0	0	12
2015	7	26	3	56	52	31	0	0	0	0	0	0	0	71.65	0	0	12
2015	7	26	4	6	52	31	0	0	0	0	0	0	0	71.51	0	0	12
2015	7	26	4	16	52	31	0	0	0	0	0	0	0	71.4	0	0	12
2015	7	26	4	26	52	30	0	0	0	0	0	0	0	71.26	0	0	12
2015	7	26	4	36	52	30	0	0	0	0	0	0	0	71.13	0	0	12
2015	7	26	4	46	52	30	0	0	0	0	0	0	0	71.02	0	0	12
2015	7	26	4	56	52	30	0	0	0	0	0	0	0	70.92	0	0	12
2015	7	26	5	6	52	31	0	0	0	0	0	0	0	70.79	0	0	12
2015	7	26	5	16	52	31	0	0	0	0	0	0	0	70.66	0	0	12
2015	7	26	5	26	52	30	0	0	0	0	0	0	0	70.54	0	0	11.8
2015	7	26	5	36	52	31	0	0	0	0	0	0	0	70.45	0	0	11.8
2015	7	26	5	46	52	31	0	0	0	0	0	0	0	70.34	0	0	11.8
2015	7	26	5	56	52	31	0	0	0	0	0	0	0	70.23	0	0	11.8
2015	7	26	6	6	52	31	0	0	0	0	0	0	0	70.14	0	0	11.8
2015	7	26	6	16	52	31	0	0	0	0	0	0	0	70.03	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	26	6	26	52	31	0	0	0	0	0	0	0	69.94	0	0	11.8
2015	7	26	6	36	52	31	0	0	0	0	0	0	0	69.85	0	0	11.8
2015	7	26	6	46	52	31	0	0	0	0	0	0	0	69.76	0	0	12
2015	7	26	6	56	52	32	0	0	0	0	0	0	0	69.69	0	0	12
2015	7	26	7	6	52	31	0	0	0	0	0	0	0	69.8	0	0	12.2
2015	7	26	7	16	52	31	0	0	0	0	0	0	0	69.84	0	0	12.4
2015	7	26	7	26	52	31	0	0	0	0	0	0	0	69.85	0	0	12.6
2015	7	26	7	36	52	31	0	0	0	0	0	0	0	69.89	0	0	12.8
2015	7	26	7	46	52	31	0	0	0	0	0	0	0	69.82	0	0	12.8
2015	7	26	7	56	52	30	0	0	0	0	0	0	0	69.82	0	0	13
2015	7	26	8	6	52	31	0	0	0	0	0	0	0	70.02	0	0	13
2015	7	26	8	16	52	32	0	0	0	0	0	0	0	70.12	0	0	13
2015	7	26	8	26	52	31	0	0	0	0	0	0	0	70.25	0	0	13
2015	7	26	8	36	52	31	0	0	0	0	0	0	0	70.36	0	0	13.2
2015	7	26	8	46	52	31	0	0	0	0	0	0	0	70.47	0	0	13.2
2015	7	26	8	56	52	31	0	0	0	0	0	0	0	70.56	0	0	13.2
2015	7	26	9	6	52	32	0	0	0	0	0	0	0	70.66	0	0	13.2
2015	7	26	9	16	52	31	0	0	0	0	0	0	0	70.79	0	0	13.4
2015	7	26	9	26	52	31	0	0	0	0	0	0	0	70.88	0	0	13.2
2015	7	26	9	36	52	30	0	0	0	0	0	0	0	70.99	0	0	13.2
2015	7	26	9	46	52	31	0	0	0	0	0	0	0	71.15	0	0	13.2
2015	7	26	9	56	52	31	0	0	0	0	0	0	0	71.29	0	0	13.2
2015	7	26	10	6	52	31	0	0	0	0	0	0	0	71.4	0	0	13.2
2015	7	26	10	16	52	31	0	0	0	0	0	0	0	71.6	0	0	13.4
2015	7	26	10	26	52	31	0	0	0	0	0	0	0	71.73	0	0	13.2
2015	7	26	10	36	52	31	0	0	0	0	0	0	0	71.89	0	0	13.2
2015	7	26	10	46	52	31	0	0	0	0	0	0	0	72.03	0	0	13.2
2015	7	26	10	56	52	31	0	0	0	0	0	0	0	72.25	0	0	13.2
2015	7	26	11	6	52	31	0	0	0	0	0	0	0	72.39	0	0	13.2
2015	7	26	11	16	52	31	0	0	0	0	0	0	0	72.59	0	0	13.2
2015	7	26	11	26	52	31	0	0	0	0	0	0	0	72.68	0	0	13.2
2015	7	26	11	36	52	30	0	0	0	0	0	0	0	72.84	0	0	13.4
2015	7	26	11	46	52	30	0	0	0	0	0	0	0	72.03	0	0	13.4
2015	7	26	11	56	52	31	0	0	0	0	0	0	0	72.01	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	26	12	6	52	30	0	0	0	0	0	0	0	72.14	0	0	13.4
2015	7	26	12	16	52	30	0	0	0	0	0	0	0	72.32	0	0	13.4
2015	7	26	12	26	52	31	0	0	0	0	0	0	0	72.52	0	0	13.4
2015	7	26	12	36	52	31	0	0	0	0	0	0	0	72.73	0	0	13.4
2015	7	26	12	46	52	31	0	0	0	0	0	0	0	73	0	0	13.4
2015	7	26	12	56	52	31	0	0	0	0	0	0	0	73.26	0	0	13.4
2015	7	26	13	6	52	31	0	0	0	0	0	0	0	74.34	0	0	13.2
2015	7	26	13	16	52	31	0	0	0	0	0	0	0	74.8	0	0	13.2
2015	7	26	13	26	52	31	0	0	0	0	0	0	0	75.11	0	0	13.2
2015	7	26	13	36	52	30	0	0	0	0	0	0	0	75.33	0	0	13.2
2015	7	26	13	46	52	30	0	0	0	0	0	0	0	75.56	0	0	13.2
2015	7	26	13	56	52	30	0	0	0	0	0	0	0	75.76	0	0	13.2
2015	7	26	14	6	52	29	0	0	0	0	0	0	0	75.94	0	0	13.2
2015	7	26	14	16	52	31	0	0	0	0	0	0	0	76.12	0	0	13.2
2015	7	26	14	26	52	29	0	0	0	0	0	0	0	76.28	0	0	13.2
2015	7	26	14	36	52	30	0	0	0	0	0	0	0	76.46	0	0	13.2
2015	7	26	14	46	52	30	0	0	0	0	0	0	0	76.62	0	0	13.2
2015	7	26	14	56	52	30	0	0	0	0	0	0	0	76.78	0	0	13.2
2015	7	26	15	6	52	30	0	0	0	0	0	0	0	76.93	0	0	13.2
2015	7	26	15	16	52	30	0	0	0	0	0	0	0	77.04	0	0	13.2
2015	7	26	15	26	52	30	0	0	0	0	0	0	0	77.16	0	0	13.2
2015	7	26	15	36	52	30	0	0	0	0	0	0	0	77.25	0	0	13.2
2015	7	26	15	46	52	30	0	0	0	0	0	0	0	77.32	0	0	13.2
2015	7	26	15	56	52	30	0	0	0	0	0	0	0	77.36	0	0	13
2015	7	26	16	6	52	30	0	0	0	0	0	0	0	77.4	0	0	13
2015	7	26	16	16	52	31	0	0	0	0	0	0	0	77.43	0	0	13
2015	7	26	16	26	52	30	0	0	0	0	0	0	0	77.49	0	0	12.8
2015	7	26	16	36	52	30	0	0	0	0	0	0	0	77.52	0	0	12.6
2015	7	26	16	46	52	30	0	0	0	0	0	0	0	77.58	0	0	12.6
2015	7	26	16	56	52	31	0	0	0	0	0	0	0	77.61	0	0	12.4
2015	7	26	17	6	52	30	0	0	0	0	0	0	0	77.67	0	0	12.4
2015	7	26	17	16	52	29	0	0	0	0	0	0	0	77.7	0	0	12.4
2015	7	26	17	26	52	30	0	0	0	0	0	0	0	77.7	0	0	12.2
2015	7	26	17	36	52	30	0	0	0	0	0	0	0	77.56	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	26	17	46	52	30	0	0	0	0	0	0	0	77.49	0	0	12.2
2015	7	26	17	56	52	30	0	0	0	0	0	0	0	77.47	0	0	12.2
2015	7	26	18	6	52	30	0	0	0	0	0	0	0	77.49	0	0	12.2
2015	7	26	18	16	52	30	0	0	0	0	0	0	0	77.5	0	0	12.2
2015	7	26	18	26	52	31	0	0	0	0	0	0	0	77.5	0	0	12.2
2015	7	26	18	36	52	31	0	0	0	0	0	0	0	77.49	0	0	12.2
2015	7	26	18	46	52	30	0	0	0	0	0	0	0	77.5	0	0	12.2
2015	7	26	18	56	52	30	0	0	0	0	0	0	0	77.5	0	0	12.2
2015	7	26	19	6	52	30	0	0	0	0	0	0	0	77.49	0	0	12.2
2015	7	26	19	16	52	31	0	0	0	0	0	0	0	77.47	0	0	12.2
2015	7	26	19	26	52	30	0	0	0	0	0	0	0	77.47	0	0	12.2
2015	7	26	19	36	52	30	0	0	0	0	0	0	0	77.43	0	0	12.2
2015	7	26	19	46	52	29	0	0	0	0	0	0	0	77.38	0	0	12.2
2015	7	26	19	56	52	30	0	0	0	0	0	0	0	77.34	0	0	12.2
2015	7	26	20	6	52	31	0	0	0	0	0	0	0	77.27	0	0	12.2
2015	7	26	20	16	52	30	0	0	0	0	0	0	0	77.2	0	0	12.2
2015	7	26	20	26	52	30	0	0	0	0	0	0	0	77.11	0	0	12.2
2015	7	26	20	36	52	30	0	0	0	0	0	0	0	77.02	0	0	12.2
2015	7	26	20	46	52	31	0	0	0	0	0	0	0	76.93	0	0	12.2
2015	7	26	20	56	52	30	0	0	0	0	0	0	0	76.82	0	0	12.2
2015	7	26	21	6	52	30	0	0	0	0	0	0	0	76.71	0	0	12
2015	7	26	21	16	52	31	0	0	0	0	0	0	0	76.6	0	0	12
2015	7	26	21	26	52	31	0	0	0	0	0	0	0	76.46	0	0	12
2015	7	26	21	36	52	30	0	0	0	0	0	0	0	76.32	0	0	12
2015	7	26	21	46	52	30	0	0	0	0	0	0	0	76.15	0	0	12
2015	7	26	21	56	52	31	0	0	0	0	0	0	0	75.99	0	0	12
2015	7	26	22	6	52	30	0	0	0	0	0	0	0	75.81	0	0	12
2015	7	26	22	16	52	31	0	0	0	0	0	0	0	75.61	0	0	12
2015	7	26	22	26	52	30	0	0	0	0	0	0	0	75.42	0	0	12
2015	7	26	22	36	52	30	0	0	0	0	0	0	0	75.24	0	0	12
2015	7	26	22	46	52	30	0	0	0	0	0	0	0	75.04	0	0	12
2015	7	26	22	56	52	31	0	0	0	0	0	0	0	74.84	0	0	12
2015	7	26	23	6	52	30	0	0	0	0	0	0	0	74.66	0	0	12
2015	7	26	23	16	52	30	0	0	0	0	0	0	0	74.5	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	26	23	26	52	30	0	0	0	0	0	0	0	74.3	0	0	12
2015	7	26	23	36	52	30	0	0	0	0	0	0	0	74.16	0	0	12
2015	7	26	23	46	52	30	0	0	0	0	0	0	0	74.01	0	0	12
2015	7	26	23	56	52	30	0	0	0	0	0	0	0	73.89	0	0	12
2015	7	27	0	6	52	31	0	0	0	0	0	0	0	73.76	0	0	12
2015	7	27	0	16	52	30	0	0	0	0	0	0	0	73.65	0	0	12
2015	7	27	0	26	52	31	0	0	0	0	0	0	0	73.53	0	0	12
2015	7	27	0	36	52	31	0	0	0	0	0	0	0	73.4	0	0	12
2015	7	27	0	46	52	31	0	0	0	0	0	0	0	73.27	0	0	12
2015	7	27	0	56	52	31	0	0	0	0	0	0	0	73.15	0	0	12
2015	7	27	1	6	52	30	0	0	0	0	0	0	0	73.02	0	0	12
2015	7	27	1	16	52	31	0	0	0	0	0	0	0	72.88	0	0	12
2015	7	27	1	26	52	30	0	0	0	0	0	0	0	72.77	0	0	12
2015	7	27	1	36	52	31	0	0	0	0	0	0	0	72.64	0	0	12
2015	7	27	1	46	52	31	0	0	0	0	0	0	0	72.54	0	0	12
2015	7	27	1	56	52	30	0	0	0	0	0	0	0	72.41	0	0	12
2015	7	27	2	6	52	31	0	0	0	0	0	0	0	72.3	0	0	12
2015	7	27	2	16	52	30	0	0	0	0	0	0	0	72.21	0	0	12
2015	7	27	2	26	52	30	0	0	0	0	0	0	0	72.1	0	0	12
2015	7	27	2	36	52	31	0	0	0	0	0	0	0	72	0	0	12
2015	7	27	2	46	52	31	0	0	0	0	0	0	0	71.89	0	0	12
2015	7	27	2	56	52	30	0	0	0	0	0	0	0	71.78	0	0	12
2015	7	27	3	6	52	31	0	0	0	0	0	0	0	71.67	0	0	12
2015	7	27	3	16	52	30	0	0	0	0	0	0	0	71.55	0	0	12
2015	7	27	3	26	52	31	0	0	0	0	0	0	0	71.42	0	0	12
2015	7	27	3	36	52	31	0	0	0	0	0	0	0	71.29	0	0	12
2015	7	27	3	46	52	30	0	0	0	0	0	0	0	71.17	0	0	12
2015	7	27	3	56	52	31	0	0	0	0	0	0	0	71.01	0	0	12
2015	7	27	4	6	52	31	0	0	0	0	0	0	0	70.88	0	0	12
2015	7	27	4	16	52	31	0	0	0	0	0	0	0	70.74	0	0	12
2015	7	27	4	26	52	31	0	0	0	0	0	0	0	70.59	0	0	12
2015	7	27	4	36	52	31	0	0	0	0	0	0	0	70.47	0	0	12
2015	7	27	4	46	52	31	0	0	0	0	0	0	0	70.34	0	0	12
2015	7	27	4	56	52	31	0	0	0	0	0	0	0	70.21	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	27	5	6	52	31	0	0	0	0	0	0	0	70.09	0	0	12
2015	7	27	5	16	52	31	0	0	0	0	0	0	0	69.98	0	0	12
2015	7	27	5	26	52	31	0	0	0	0	0	0	0	69.85	0	0	12
2015	7	27	5	36	52	31	0	0	0	0	0	0	0	69.75	0	0	12
2015	7	27	5	46	52	31	0	0	0	0	0	0	0	69.64	0	0	12
2015	7	27	5	56	52	31	0	0	0	0	0	0	0	69.53	0	0	12
2015	7	27	6	6	52	31	0	0	0	0	0	0	0	69.4	0	0	12
2015	7	27	6	16	52	31	0	0	0	0	0	0	0	69.3	0	0	12
2015	7	27	6	26	52	31	0	0	0	0	0	0	0	69.21	0	0	12
2015	7	27	6	36	52	31	0	0	0	0	0	0	0	69.1	0	0	12
2015	7	27	6	46	52	31	0	0	0	0	0	0	0	68.99	0	0	12
2015	7	27	6	56	52	31	0	0	0	0	0	0	0	68.88	0	0	12
2015	7	27	7	6	52	31	0	0	0	0	0	0	0	68.99	0	0	12.2
2015	7	27	7	16	52	31	0	0	0	0	0	0	0	68.99	0	0	12.4
2015	7	27	7	26	52	30	0	0	0	0	0	0	0	68.97	0	0	12.6
2015	7	27	7	36	52	31	0	0	0	0	0	0	0	68.95	0	0	12.6
2015	7	27	7	46	52	31	0	0	0	0	0	0	0	68.72	0	0	12.8
2015	7	27	7	56	52	32	0	0	0	0	0	0	0	68.63	0	0	13
2015	7	27	8	6	52	31	0	0	0	0	0	0	0	68.86	0	0	13
2015	7	27	8	16	52	31	0	0	0	0	0	0	0	68.92	0	0	13
2015	7	27	8	26	52	31	0	0	0	0	0	0	0	68.97	0	0	13
2015	7	27	8	36	52	31	0	0	0	0	0	0	0	68.97	0	0	13.2
2015	7	27	8	46	52	31	0	0	0	0	0	0	0	69.01	0	0	13.2
2015	7	27	8	56	52	31	0	0	0	0	0	0	0	69.03	0	0	13.2
2015	7	27	9	6	52	31	0	0	0	0	0	0	0	69.12	0	0	13.2
2015	7	27	9	16	52	31	0	0	0	0	0	0	0	69.08	0	0	13.4
2015	7	27	9	26	52	31	0	0	0	0	0	0	0	69.19	0	0	13.4
2015	7	27	9	36	52	31	0	0	0	0	0	0	0	69.26	0	0	13.4
2015	7	27	9	46	52	31	0	0	0	0	0	0	0	69.3	0	0	13.4
2015	7	27	9	56	52	31	0	0	0	0	0	0	0	69.37	0	0	13.4
2015	7	27	10	6	52	31	0	0	0	0	0	0	0	69.46	0	0	13.4
2015	7	27	10	16	52	32	0	0	0	0	0	0	0	69.58	0	0	13.4
2015	7	27	10	26	52	31	0	0	0	0	0	0	0	69.71	0	0	13.4
2015	7	27	10	36	52	31	0	0	0	0	0	0	0	69.8	0	0	13.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	27	10	46	52	31	0	0	0	0	0	0	0	69.91	0	0	13.4
2015	7	27	10	56	52	32	0	0	0	0	0	0	0	70.05	0	0	13.4
2015	7	27	11	6	52	30	0	0	0	0	0	0	0	70.18	0	0	13.4
2015	7	27	11	16	52	31	0	0	0	0	0	0	0	70.39	0	0	13.4
2015	7	27	11	26	52	31	0	0	0	0	0	0	0	70.54	0	0	13.4
2015	7	27	11	36	52	31	0	0	0	0	0	0	0	70.63	0	0	13.4
2015	7	27	11	46	52	30	0	0	0	0	0	0	0	69.78	0	0	13.4
2015	7	27	11	56	52	31	0	0	0	0	0	0	0	69.75	0	0	13.4
2015	7	27	12	6	52	32	0	0	0	0	0	0	0	69.87	0	0	13.4
2015	7	27	12	16	52	31	0	0	0	0	0	0	0	70.07	0	0	13.2
2015	7	27	12	26	52	32	0	0	0	0	0	0	0	70.32	0	0	13.2
2015	7	27	12	36	52	31	0	0	0	0	0	0	0	70.57	0	0	13.2
2015	7	27	12	46	52	32	0	0	0	0	0	0	0	70.86	0	0	13.2
2015	7	27	12	56	52	31	0	0	0	0	0	0	0	71.2	0	0	13.2
2015	7	27	13	6	52	31	0	0	0	0	0	0	0	72.39	0	0	13.2
2015	7	27	13	16	52	31	0	0	0	0	0	0	0	72.93	0	0	13.2
2015	7	27	13	26	52	31	0	0	0	0	0	0	0	73.26	0	0	13.2
2015	7	27	13	36	52	31	0	0	0	0	0	0	0	73.58	0	0	13.2
2015	7	27	13	46	52	30	0	0	0	0	0	0	0	73.89	0	0	13.2
2015	7	27	13	56	52	31	0	0	0	0	0	0	0	74.14	0	0	13.2
2015	7	27	14	6	52	31	0	0	0	0	0	0	0	74.39	0	0	13.2
2015	7	27	14	16	52	31	0	0	0	0	0	0	0	74.62	0	0	13.2
2015	7	27	14	26	52	30	0	0	0	0	0	0	0	74.88	0	0	13.2
2015	7	27	14	36	52	31	0	0	0	0	0	0	0	75.07	0	0	13.2
2015	7	27	14	46	52	30	0	0	0	0	0	0	0	75.25	0	0	13.2
2015	7	27	14	56	52	31	0	0	0	0	0	0	0	75.4	0	0	13.2
2015	7	27	15	6	52	30	0	0	0	0	0	0	0	75.58	0	0	13.2
2015	7	27	15	16	52	30	0	0	0	0	0	0	0	75.72	0	0	13.2
2015	7	27	15	26	52	31	0	0	0	0	0	0	0	75.83	0	0	13
2015	7	27	15	36	52	30	0	0	0	0	0	0	0	75.94	0	0	13
2015	7	27	15	46	52	30	0	0	0	0	0	0	0	76.05	0	0	13
2015	7	27	15	56	52	30	0	0	0	0	0	0	0	76.14	0	0	13
2015	7	27	16	6	52	30	0	0	0	0	0	0	0	76.19	0	0	13
2015	7	27	16	16	52	31	0	0	0	0	0	0	0	76.24	0	0	13

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	27	16	26	52	31	0	0	0	0	0	0	0	76.28	0	0	12.8
2015	7	27	16	36	52	30	0	0	0	0	0	0	0	76.35	0	0	12.6
2015	7	27	16	46	52	30	0	0	0	0	0	0	0	76.39	0	0	12.6
2015	7	27	16	56	52	30	0	0	0	0	0	0	0	76.42	0	0	12.4
2015	7	27	17	6	52	30	0	0	0	0	0	0	0	76.48	0	0	12.4
2015	7	27	17	16	52	31	0	0	0	0	0	0	0	76.5	0	0	12.4
2015	7	27	17	26	52	30	0	0	0	0	0	0	0	76.5	0	0	12.2
2015	7	27	17	36	52	30	0	0	0	0	0	0	0	76.35	0	0	12.2
2015	7	27	17	46	52	31	0	0	0	0	0	0	0	76.28	0	0	12.2
2015	7	27	17	56	52	30	0	0	0	0	0	0	0	76.26	0	0	12.2
2015	7	27	18	6	52	30	0	0	0	0	0	0	0	76.28	0	0	12.2
2015	7	27	18	16	52	30	0	0	0	0	0	0	0	76.32	0	0	12.2
2015	7	27	18	26	52	31	0	0	0	0	0	0	0	76.33	0	0	12.2
2015	7	27	18	36	52	30	0	0	0	0	0	0	0	76.37	0	0	12.2
2015	7	27	18	46	52	31	0	0	0	0	0	0	0	76.39	0	0	12.2
2015	7	27	18	56	52	31	0	0	0	0	0	0	0	76.39	0	0	12.2
2015	7	27	19	6	52	30	0	0	0	0	0	0	0	76.41	0	0	12.2
2015	7	27	19	16	52	30	0	0	0	0	0	0	0	76.39	0	0	12.2
2015	7	27	19	26	52	31	0	0	0	0	0	0	0	76.39	0	0	12.2
2015	7	27	19	36	52	30	0	0	0	0	0	0	0	76.35	0	0	12.2
2015	7	27	19	46	52	30	0	0	0	0	0	0	0	76.3	0	0	12.2
2015	7	27	19	56	52	30	0	0	0	0	0	0	0	76.23	0	0	12.2
2015	7	27	20	6	52	30	0	0	0	0	0	0	0	76.17	0	0	12.2
2015	7	27	20	16	52	30	0	0	0	0	0	0	0	76.1	0	0	12.2
2015	7	27	20	26	52	30	0	0	0	0	0	0	0	76.03	0	0	12.2
2015	7	27	20	36	52	30	0	0	0	0	0	0	0	75.92	0	0	12.2
2015	7	27	20	46	52	31	0	0	0	0	0	0	0	75.81	0	0	12.2
2015	7	27	20	56	52	30	0	0	0	0	0	0	0	75.72	0	0	12
2015	7	27	21	6	52	30	0	0	0	0	0	0	0	75.61	0	0	12
2015	7	27	21	16	52	30	0	0	0	0	0	0	0	75.51	0	0	12
2015	7	27	21	26	52	30	0	0	0	0	0	0	0	75.36	0	0	12
2015	7	27	21	36	52	31	0	0	0	0	0	0	0	75.22	0	0	12
2015	7	27	21	46	52	30	0	0	0	0	0	0	0	75.11	0	0	12
2015	7	27	21	56	52	31	0	0	0	0	0	0	0	74.95	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	27	22	6	52	30	0	0	0	0	0	0	0	74.79	0	0	12
2015	7	27	22	16	52	30	0	0	0	0	0	0	0	74.64	0	0	12
2015	7	27	22	26	52	30	0	0	0	0	0	0	0	74.48	0	0	12
2015	7	27	22	36	52	30	0	0	0	0	0	0	0	74.3	0	0	12
2015	7	27	22	46	52	30	0	0	0	0	0	0	0	74.12	0	0	12
2015	7	27	22	56	52	31	0	0	0	0	0	0	0	73.94	0	0	12
2015	7	27	23	6	52	31	0	0	0	0	0	0	0	73.74	0	0	12
2015	7	27	23	16	52	31	0	0	0	0	0	0	0	73.56	0	0	12
2015	7	27	23	26	52	31	0	0	0	0	0	0	0	73.36	0	0	12
2015	7	27	23	36	52	31	0	0	0	0	0	0	0	73.18	0	0	12
2015	7	27	23	46	52	31	0	0	0	0	0	0	0	73.02	0	0	12
2015	7	27	23	56	52	30	0	0	0	0	0	0	0	72.86	0	0	12
2015	7	28	0	6	52	30	0	0	0	0	0	0	0	72.7	0	0	12
2015	7	28	0	16	52	30	0	0	0	0	0	0	0	72.54	0	0	12
2015	7	28	0	26	52	30	0	0	0	0	0	0	0	72.37	0	0	12
2015	7	28	0	36	52	30	0	0	0	0	0	0	0	72.21	0	0	12
2015	7	28	0	46	52	31	0	0	0	0	0	0	0	72.05	0	0	12
2015	7	28	0	56	52	31	0	0	0	0	0	0	0	71.91	0	0	12
2015	7	28	1	6	52	30	0	0	0	0	0	0	0	71.76	0	0	12
2015	7	28	1	16	52	31	0	0	0	0	0	0	0	71.62	0	0	12
2015	7	28	1	26	52	31	0	0	0	0	0	0	0	71.49	0	0	12
2015	7	28	1	36	52	31	0	0	0	0	0	0	0	71.38	0	0	12
2015	7	28	1	46	52	31	0	0	0	0	0	0	0	71.24	0	0	12
2015	7	28	1	56	52	31	0	0	0	0	0	0	0	71.13	0	0	12
2015	7	28	2	6	52	31	0	0	0	0	0	0	0	71.01	0	0	12
2015	7	28	2	16	52	31	0	0	0	0	0	0	0	70.88	0	0	12
2015	7	28	2	26	52	30	0	0	0	0	0	0	0	70.77	0	0	12
2015	7	28	2	36	52	31	0	0	0	0	0	0	0	70.66	0	0	12
2015	7	28	2	46	52	30	0	0	0	0	0	0	0	70.54	0	0	12
2015	7	28	2	56	52	31	0	0	0	0	0	0	0	70.43	0	0	12
2015	7	28	3	6	52	30	0	0	0	0	0	0	0	70.3	0	0	12
2015	7	28	3	16	52	31	0	0	0	0	0	0	0	70.18	0	0	12
2015	7	28	3	26	52	31	0	0	0	0	0	0	0	70.05	0	0	12
2015	7	28	3	36	52	31	0	0	0	0	0	0	0	69.93	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	28	3	46	52	32	0	0	0	0	0	0	0	69.82	0	0	12
2015	7	28	3	56	52	31	0	0	0	0	0	0	0	69.69	0	0	12
2015	7	28	4	6	52	30	0	0	0	0	0	0	0	69.57	0	0	12
2015	7	28	4	16	52	32	0	0	0	0	0	0	0	69.44	0	0	12
2015	7	28	4	26	52	31	0	0	0	0	0	0	0	69.33	0	0	12
2015	7	28	4	36	52	31	0	0	0	0	0	0	0	69.22	0	0	12
2015	7	28	4	46	52	31	0	0	0	0	0	0	0	69.1	0	0	12
2015	7	28	4	56	52	31	0	0	0	0	0	0	0	68.99	0	0	12
2015	7	28	5	6	52	32	0	0	0	0	0	0	0	68.88	0	0	12
2015	7	28	5	16	52	31	0	0	0	0	0	0	0	68.77	0	0	12
2015	7	28	5	26	52	31	0	0	0	0	0	0	0	68.68	0	0	12
2015	7	28	5	36	52	32	0	0	0	0	0	0	0	68.58	0	0	12
2015	7	28	5	46	52	31	0	0	0	0	0	0	0	68.47	0	0	12
2015	7	28	5	56	52	31	0	0	0	0	0	0	0	68.38	0	0	12
2015	7	28	6	6	52	31	0	0	0	0	0	0	0	68.29	0	0	12
2015	7	28	6	16	52	31	0	0	0	0	0	0	0	68.2	0	0	12
2015	7	28	6	26	52	31	0	0	0	0	0	0	0	68.11	0	0	12
2015	7	28	6	36	52	32	0	0	0	0	0	0	0	68.04	0	0	12
2015	7	28	6	46	52	32	0	0	0	0	0	0	0	67.95	0	0	12
2015	7	28	6	56	52	31	0	0	0	0	0	0	0	67.87	0	0	12
2015	7	28	7	6	52	31	0	0	0	0	0	0	0	68	0	0	12.2
2015	7	28	7	16	52	31	0	0	0	0	0	0	0	68.02	0	0	12.4
2015	7	28	7	26	52	31	0	0	0	0	0	0	0	68.02	0	0	12.6
2015	7	28	7	36	52	31	0	0	0	0	0	0	0	68.04	0	0	12.6
2015	7	28	7	46	52	31	0	0	0	0	0	0	0	67.68	0	0	12.8
2015	7	28	7	56	52	31	0	0	0	0	0	0	0	67.6	0	0	12.8
2015	7	28	8	6	52	31	0	0	0	0	0	0	0	68.02	0	0	13
2015	7	28	8	16	52	31	0	0	0	0	0	0	0	68.07	0	0	13
2015	7	28	8	26	52	32	0	0	0	0	0	0	0	68.11	0	0	13
2015	7	28	8	36	52	31	0	0	0	0	0	0	0	68.14	0	0	13
2015	7	28	8	46	52	31	0	0	0	0	0	0	0	68.2	0	0	13.2
2015	7	28	8	56	52	32	0	0	0	0	0	0	0	68.27	0	0	13.2
2015	7	28	9	6	52	31	0	0	0	0	0	0	0	68.34	0	0	13.2
2015	7	28	9	16	52	31	0	0	0	0	0	0	0	68.36	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	28	9	26	52	31	0	0	0	0	0	0	0	68.49	0	0	13.2
2015	7	28	9	36	52	32	0	0	0	0	0	0	0	68.54	0	0	13.2
2015	7	28	9	46	52	31	0	0	0	0	0	0	0	68.61	0	0	13.4
2015	7	28	9	56	52	31	0	0	0	0	0	0	0	68.7	0	0	13.4
2015	7	28	10	6	52	31	0	0	0	0	0	0	0	68.81	0	0	13.4
2015	7	28	10	16	52	31	0	0	0	0	0	0	0	68.95	0	0	13.4
2015	7	28	10	26	52	31	0	0	0	0	0	0	0	69.06	0	0	13.4
2015	7	28	10	36	52	32	0	0	0	0	0	0	0	69.21	0	0	13.4
2015	7	28	10	46	52	31	0	0	0	0	0	0	0	69.39	0	0	13.4
2015	7	28	10	56	52	31	0	0	0	0	0	0	0	69.57	0	0	13.4
2015	7	28	11	6	52	31	0	0	0	0	0	0	0	69.67	0	0	13.2
2015	7	28	11	16	52	31	0	0	0	0	0	0	0	69.89	0	0	13.2
2015	7	28	11	26	52	31	0	0	0	0	0	0	0	70.07	0	0	13.2
2015	7	28	11	36	52	31	0	0	0	0	0	0	0	70.09	0	0	13.2
2015	7	28	11	46	52	32	0	0	0	0	0	0	0	69.48	0	0	13.2
2015	7	28	11	56	52	31	0	0	0	0	0	0	0	69.55	0	0	13.2
2015	7	28	12	6	52	31	0	0	0	0	0	0	0	69.76	0	0	13.2
2015	7	28	12	16	52	31	0	0	0	0	0	0	0	70	0	0	13.2
2015	7	28	12	26	52	31	0	0	0	0	0	0	0	70.27	0	0	13.2
2015	7	28	12	36	52	31	0	0	0	0	0	0	0	70.56	0	0	13.2
2015	7	28	12	46	52	30	0	0	0	0	0	0	0	70.88	0	0	13.2
2015	7	28	12	56	52	31	0	0	0	0	0	0	0	71.29	0	0	13.2
2015	7	28	13	6	52	31	0	0	0	0	0	0	0	72.32	0	0	13.2
2015	7	28	13	16	52	31	0	0	0	0	0	0	0	72.79	0	0	13.2
2015	7	28	13	26	52	30	0	0	0	0	0	0	0	73.17	0	0	13.2
2015	7	28	13	36	52	30	0	0	0	0	0	0	0	73.42	0	0	13.2
2015	7	28	13	46	52	31	0	0	0	0	0	0	0	73.72	0	0	13.2
2015	7	28	13	56	52	30	0	0	0	0	0	0	0	73.96	0	0	13.2
2015	7	28	14	6	52	31	0	0	0	0	0	0	0	74.19	0	0	13.2
2015	7	28	14	16	52	31	0	0	0	0	0	0	0	74.44	0	0	13.2
2015	7	28	14	26	52	30	0	0	0	0	0	0	0	74.7	0	0	13.2
2015	7	28	14	36	52	30	0	0	0	0	0	0	0	74.89	0	0	13.2
2015	7	28	14	46	52	31	0	0	0	0	0	0	0	75.06	0	0	13.2
2015	7	28	14	56	52	30	0	0	0	0	0	0	0	75.27	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	28	15	6	52	31	0	0	0	0	0	0	0	75.42	0	0	13.2
2015	7	28	15	16	52	30	0	0	0	0	0	0	0	75.56	0	0	13.2
2015	7	28	15	26	52	30	0	0	0	0	0	0	0	75.7	0	0	13
2015	7	28	15	36	52	31	0	0	0	0	0	0	0	75.83	0	0	13
2015	7	28	15	46	52	31	0	0	0	0	0	0	0	75.9	0	0	13
2015	7	28	15	56	52	30	0	0	0	0	0	0	0	75.97	0	0	13
2015	7	28	16	6	52	31	0	0	0	0	0	0	0	76.08	0	0	13
2015	7	28	16	16	52	30	0	0	0	0	0	0	0	76.15	0	0	12.8
2015	7	28	16	26	52	30	0	0	0	0	0	0	0	76.23	0	0	12.8
2015	7	28	16	36	52	30	0	0	0	0	0	0	0	76.24	0	0	12.6
2015	7	28	16	46	52	30	0	0	0	0	0	0	0	76.26	0	0	12.6
2015	7	28	16	56	52	30	0	0	0	0	0	0	0	76.32	0	0	12.4
2015	7	28	17	6	52	30	0	0	0	0	0	0	0	76.33	0	0	12.4
2015	7	28	17	16	52	30	0	0	0	0	0	0	0	76.35	0	0	12.4
2015	7	28	17	26	52	30	0	0	0	0	0	0	0	76.37	0	0	12.2
2015	7	28	17	36	52	31	0	0	0	0	0	0	0	76.24	0	0	12.2
2015	7	28	17	46	52	31	0	0	0	0	0	0	0	76.21	0	0	12.2
2015	7	28	17	56	52	30	0	0	0	0	0	0	0	76.23	0	0	12.2
2015	7	28	18	6	52	30	0	0	0	0	0	0	0	76.23	0	0	12.2
2015	7	28	18	16	52	30	0	0	0	0	0	0	0	76.26	0	0	12.2
2015	7	28	18	26	52	30	0	0	0	0	0	0	0	76.3	0	0	12.2
2015	7	28	18	36	52	30	0	0	0	0	0	0	0	76.32	0	0	12.2
2015	7	28	18	46	52	30	0	0	0	0	0	0	0	76.33	0	0	12.2
2015	7	28	18	56	52	30	0	0	0	0	0	0	0	76.35	0	0	12.2
2015	7	28	19	6	52	30	0	0	0	0	0	0	0	76.35	0	0	12.2
2015	7	28	19	16	52	30	0	0	0	0	0	0	0	76.35	0	0	12.2
2015	7	28	19	26	52	30	0	0	0	0	0	0	0	76.33	0	0	12.2
2015	7	28	19	36	52	30	0	0	0	0	0	0	0	76.3	0	0	12.2
2015	7	28	19	46	52	31	0	0	0	0	0	0	0	76.26	0	0	12.2
2015	7	28	19	56	52	30	0	0	0	0	0	0	0	76.21	0	0	12.2
2015	7	28	20	6	52	30	0	0	0	0	0	0	0	76.14	0	0	12.2
2015	7	28	20	16	52	30	0	0	0	0	0	0	0	76.06	0	0	12.2
2015	7	28	20	26	52	31	0	0	0	0	0	0	0	75.97	0	0	12.2
2015	7	28	20	36	52	30	0	0	0	0	0	0	0	75.88	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	28	20	46	52	30	0	0	0	0	0	0	0	75.78	0	0	12
2015	7	28	20	56	52	30	0	0	0	0	0	0	0	75.67	0	0	12
2015	7	28	21	6	52	29	0	0	0	0	0	0	0	75.56	0	0	12
2015	7	28	21	16	52	31	0	0	0	0	0	0	0	75.43	0	0	12
2015	7	28	21	26	52	30	0	0	0	0	0	0	0	75.29	0	0	12
2015	7	28	21	36	52	31	0	0	0	0	0	0	0	75.16	0	0	12
2015	7	28	21	46	52	30	0	0	0	0	0	0	0	75.02	0	0	12
2015	7	28	21	56	52	31	0	0	0	0	0	0	0	74.88	0	0	12
2015	7	28	22	6	52	30	0	0	0	0	0	0	0	74.73	0	0	12
2015	7	28	22	16	52	31	0	0	0	0	0	0	0	74.57	0	0	12
2015	7	28	22	26	52	31	0	0	0	0	0	0	0	74.41	0	0	12
2015	7	28	22	36	52	30	0	0	0	0	0	0	0	74.26	0	0	12
2015	7	28	22	46	52	31	0	0	0	0	0	0	0	74.08	0	0	12
2015	7	28	22	56	52	31	0	0	0	0	0	0	0	73.92	0	0	12
2015	7	28	23	6	52	31	0	0	0	0	0	0	0	73.76	0	0	12
2015	7	28	23	16	52	30	0	0	0	0	0	0	0	73.6	0	0	12
2015	7	28	23	26	52	31	0	0	0	0	0	0	0	73.44	0	0	12
2015	7	28	23	36	52	31	0	0	0	0	0	0	0	73.29	0	0	12
2015	7	28	23	46	52	31	0	0	0	0	0	0	0	73.15	0	0	12
2015	7	28	23	56	52	30	0	0	0	0	0	0	0	73	0	0	12
2015	7	29	0	6	52	31	0	0	0	0	0	0	0	72.88	0	0	12
2015	7	29	0	16	52	31	0	0	0	0	0	0	0	72.73	0	0	12
2015	7	29	0	26	52	31	0	0	0	0	0	0	0	72.59	0	0	12
2015	7	29	0	36	52	30	0	0	0	0	0	0	0	72.45	0	0	12
2015	7	29	0	46	52	30	0	0	0	0	0	0	0	72.28	0	0	12
2015	7	29	0	56	52	31	0	0	0	0	0	0	0	72.14	0	0	12
2015	7	29	1	6	52	31	0	0	0	0	0	0	0	72.01	0	0	12
2015	7	29	1	16	52	31	0	0	0	0	0	0	0	71.87	0	0	12
2015	7	29	1	26	52	31	0	0	0	0	0	0	0	71.74	0	0	12
2015	7	29	1	36	52	31	0	0	0	0	0	0	0	71.62	0	0	12
2015	7	29	1	46	52	30	0	0	0	0	0	0	0	71.49	0	0	12
2015	7	29	1	56	52	30	0	0	0	0	0	0	0	71.37	0	0	12
2015	7	29	2	6	52	31	0	0	0	0	0	0	0	71.24	0	0	12
2015	7	29	2	16	52	31	0	0	0	0	0	0	0	71.13	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	29	2	26	52	31	0	0	0	0	0	0	0	71.02	0	0	12
2015	7	29	2	36	52	31	0	0	0	0	0	0	0	70.92	0	0	12
2015	7	29	2	46	52	32	0	0	0	0	0	0	0	70.81	0	0	12
2015	7	29	2	56	52	31	0	0	0	0	0	0	0	70.7	0	0	12
2015	7	29	3	6	52	31	0	0	0	0	0	0	0	70.61	0	0	12
2015	7	29	3	16	52	31	0	0	0	0	0	0	0	70.52	0	0	12
2015	7	29	3	26	52	30	0	0	0	0	0	0	0	70.43	0	0	12
2015	7	29	3	36	52	32	0	0	0	0	0	0	0	70.32	0	0	12
2015	7	29	3	46	52	31	0	0	0	0	0	0	0	70.23	0	0	12
2015	7	29	3	56	52	30	0	0	0	0	0	0	0	70.14	0	0	12
2015	7	29	4	6	52	31	0	0	0	0	0	0	0	70.05	0	0	12
2015	7	29	4	16	52	31	0	0	0	0	0	0	0	69.96	0	0	12
2015	7	29	4	26	52	30	0	0	0	0	0	0	0	69.87	0	0	12
2015	7	29	4	36	52	31	0	0	0	0	0	0	0	69.78	0	0	12
2015	7	29	4	46	52	31	0	0	0	0	0	0	0	69.69	0	0	12
2015	7	29	4	56	52	30	0	0	0	0	0	0	0	69.6	0	0	12
2015	7	29	5	6	52	31	0	0	0	0	0	0	0	69.51	0	0	12
2015	7	29	5	16	52	31	0	0	0	0	0	0	0	69.44	0	0	12
2015	7	29	5	26	52	32	0	0	0	0	0	0	0	69.35	0	0	12
2015	7	29	5	36	52	31	0	0	0	0	0	0	0	69.28	0	0	12
2015	7	29	5	46	52	31	0	0	0	0	0	0	0	69.19	0	0	12
2015	7	29	5	56	52	31	0	0	0	0	0	0	0	69.12	0	0	12
2015	7	29	6	6	52	32	0	0	0	0	0	0	0	69.04	0	0	12
2015	7	29	6	16	52	31	0	0	0	0	0	0	0	68.99	0	0	12
2015	7	29	6	26	52	31	0	0	0	0	0	0	0	68.92	0	0	12
2015	7	29	6	36	52	31	0	0	0	0	0	0	0	68.86	0	0	12
2015	7	29	6	46	52	32	0	0	0	0	0	0	0	68.79	0	0	12
2015	7	29	6	56	52	31	0	0	0	0	0	0	0	68.72	0	0	12
2015	7	29	7	6	52	31	0	0	0	0	0	0	0	68.88	0	0	12.2
2015	7	29	7	16	52	31	0	0	0	0	0	0	0	68.92	0	0	12.4
2015	7	29	7	26	52	31	0	0	0	0	0	0	0	68.92	0	0	12.6
2015	7	29	7	36	52	31	0	0	0	0	0	0	0	68.95	0	0	12.6
2015	7	29	7	46	52	32	0	0	0	0	0	0	0	68.58	0	0	12.8
2015	7	29	7	56	52	32	0	0	0	0	0	0	0	68.47	0	0	12.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	29	8	6	52	32	0	0	0	0	0	0	0	68.99	0	0	13
2015	7	29	8	16	52	31	0	0	0	0	0	0	0	69.12	0	0	13
2015	7	29	8	26	52	31	0	0	0	0	0	0	0	69.17	0	0	13
2015	7	29	8	36	52	30	0	0	0	0	0	0	0	69.28	0	0	13
2015	7	29	8	46	52	31	0	0	0	0	0	0	0	69.33	0	0	13.2
2015	7	29	8	56	52	32	0	0	0	0	0	0	0	69.46	0	0	13.2
2015	7	29	9	6	52	31	0	0	0	0	0	0	0	69.55	0	0	13.2
2015	7	29	9	16	52	31	0	0	0	0	0	0	0	69.64	0	0	13.2
2015	7	29	9	26	52	31	0	0	0	0	0	0	0	69.73	0	0	13.2
2015	7	29	9	36	52	31	0	0	0	0	0	0	0	69.78	0	0	13.2
2015	7	29	9	46	52	31	0	0	0	0	0	0	0	69.96	0	0	13.2
2015	7	29	9	56	52	32	0	0	0	0	0	0	0	70.03	0	0	13.2
2015	7	29	10	6	52	31	0	0	0	0	0	0	0	70.18	0	0	13.2
2015	7	29	10	16	52	31	0	0	0	0	0	0	0	70.32	0	0	13.2
2015	7	29	10	26	52	31	0	0	0	0	0	0	0	70.14	0	0	13.2
2015	7	29	10	36	52	32	0	0	0	0	0	0	0	70.48	0	0	13.2
2015	7	29	10	46	52	30	0	0	0	0	0	0	0	70.75	0	0	13.2
2015	7	29	10	56	52	31	0	0	0	0	0	0	0	70.99	0	0	13.2
2015	7	29	11	6	52	31	0	0	0	0	0	0	0	71.2	0	0	13.2
2015	7	29	11	16	52	31	0	0	0	0	0	0	0	71.4	0	0	13.2
2015	7	29	11	26	52	31	0	0	0	0	0	0	0	71.62	0	0	13.2
2015	7	29	11	36	52	31	0	0	0	0	0	0	0	71.56	0	0	13.2
2015	7	29	11	46	52	31	0	0	0	0	0	0	0	70.92	0	0	13.2
2015	7	29	11	56	52	31	0	0	0	0	0	0	0	71.02	0	0	13.2
2015	7	29	12	6	52	31	0	0	0	0	0	0	0	71.24	0	0	13.2
2015	7	29	12	16	52	31	0	0	0	0	0	0	0	71.47	0	0	13.2
2015	7	29	12	26	52	30	0	0	0	0	0	0	0	71.73	0	0	13.2
2015	7	29	12	36	52	31	0	0	0	0	0	0	0	72	0	0	13.2
2015	7	29	12	46	52	31	0	0	0	0	0	0	0	72.28	0	0	13.2
2015	7	29	12	56	52	32	0	0	0	0	0	0	0	72.75	0	0	13.2
2015	7	29	13	6	52	31	0	0	0	0	0	0	0	73.78	0	0	13.2
2015	7	29	13	16	52	31	0	0	0	0	0	0	0	74.23	0	0	13.2
2015	7	29	13	26	52	31	0	0	0	0	0	0	0	74.5	0	0	13.2
2015	7	29	13	36	52	30	0	0	0	0	0	0	0	74.75	0	0	13.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	29	13	46	52	30	0	0	0	0	0	0	0	75	0	0	13.2
2015	7	29	13	56	52	31	0	0	0	0	0	0	0	75.29	0	0	13.2
2015	7	29	14	6	52	31	0	0	0	0	0	0	0	75.47	0	0	13.2
2015	7	29	14	16	52	30	0	0	0	0	0	0	0	75.67	0	0	13.2
2015	7	29	14	26	52	30	0	0	0	0	0	0	0	75.9	0	0	13.2
2015	7	29	14	36	52	30	0	0	0	0	0	0	0	76.12	0	0	13.2
2015	7	29	14	46	52	31	0	0	0	0	0	0	0	76.26	0	0	13.2
2015	7	29	14	56	52	30	0	0	0	0	0	0	0	76.42	0	0	13.2
2015	7	29	15	6	52	30	0	0	0	0	0	0	0	76.62	0	0	13.2
2015	7	29	15	16	52	30	0	0	0	0	0	0	0	76.77	0	0	13
2015	7	29	15	26	52	30	0	0	0	0	0	0	0	76.89	0	0	13
2015	7	29	15	36	52	30	0	0	0	0	0	0	0	77	0	0	13
2015	7	29	15	46	52	30	0	0	0	0	0	0	0	77.09	0	0	13
2015	7	29	15	56	52	30	0	0	0	0	0	0	0	77.22	0	0	13
2015	7	29	16	6	52	30	0	0	0	0	0	0	0	77.29	0	0	13
2015	7	29	16	16	52	30	0	0	0	0	0	0	0	77.36	0	0	12.8
2015	7	29	16	26	52	30	0	0	0	0	0	0	0	77.43	0	0	12.8
2015	7	29	16	36	52	30	0	0	0	0	0	0	0	77.47	0	0	12.6
2015	7	29	16	46	52	30	0	0	0	0	0	0	0	77.52	0	0	12.6
2015	7	29	16	56	52	30	0	0	0	0	0	0	0	77.56	0	0	12.4
2015	7	29	17	6	52	30	0	0	0	0	0	0	0	77.59	0	0	12.4
2015	7	29	17	16	52	30	0	0	0	0	0	0	0	77.65	0	0	12.4
2015	7	29	17	26	52	30	0	0	0	0	0	0	0	77.67	0	0	12.2
2015	7	29	17	36	52	30	0	0	0	0	0	0	0	77.5	0	0	12.2
2015	7	29	17	46	52	30	0	0	0	0	0	0	0	77.45	0	0	12.2
2015	7	29	17	56	52	30	0	0	0	0	0	0	0	77.45	0	0	12.2
2015	7	29	18	6	52	30	0	0	0	0	0	0	0	77.49	0	0	12.2
2015	7	29	18	16	52	30	0	0	0	0	0	0	0	77.5	0	0	12.2
2015	7	29	18	26	52	30	0	0	0	0	0	0	0	77.52	0	0	12.2
2015	7	29	18	36	52	30	0	0	0	0	0	0	0	77.52	0	0	12.2
2015	7	29	18	46	52	30	0	0	0	0	0	0	0	77.52	0	0	12.2
2015	7	29	18	56	52	31	0	0	0	0	0	0	0	77.52	0	0	12.2
2015	7	29	19	6	52	30	0	0	0	0	0	0	0	77.49	0	0	12.2
2015	7	29	19	16	52	31	0	0	0	0	0	0	0	77.47	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	29	19	26	52	30	0	0	0	0	0	0	0	77.41	0	0	12.2
2015	7	29	19	36	52	30	0	0	0	0	0	0	0	77.36	0	0	12.2
2015	7	29	19	46	52	30	0	0	0	0	0	0	0	77.31	0	0	12.2
2015	7	29	19	56	52	30	0	0	0	0	0	0	0	77.25	0	0	12.2
2015	7	29	20	6	52	31	0	0	0	0	0	0	0	77.18	0	0	12.2
2015	7	29	20	16	52	30	0	0	0	0	0	0	0	77.14	0	0	12.2
2015	7	29	20	26	52	30	0	0	0	0	0	0	0	77.09	0	0	12.2
2015	7	29	20	36	52	31	0	0	0	0	0	0	0	77.04	0	0	12
2015	7	29	20	46	52	31	0	0	0	0	0	0	0	77	0	0	12
2015	7	29	20	56	52	30	0	0	0	0	0	0	0	76.95	0	0	12
2015	7	29	21	6	52	30	0	0	0	0	0	0	0	76.87	0	0	12
2015	7	29	21	16	52	30	0	0	0	0	0	0	0	76.78	0	0	12
2015	7	29	21	26	52	30	0	0	0	0	0	0	0	76.69	0	0	12
2015	7	29	21	36	52	30	0	0	0	0	0	0	0	76.59	0	0	12
2015	7	29	21	46	52	30	0	0	0	0	0	0	0	76.46	0	0	12
2015	7	29	21	56	52	30	0	0	0	0	0	0	0	76.33	0	0	12
2015	7	29	22	6	52	30	0	0	0	0	0	0	0	76.19	0	0	12
2015	7	29	22	16	52	30	0	0	0	0	0	0	0	76.06	0	0	12
2015	7	29	22	26	52	30	0	0	0	0	0	0	0	75.92	0	0	12
2015	7	29	22	36	52	31	0	0	0	0	0	0	0	75.81	0	0	12
2015	7	29	22	46	52	30	0	0	0	0	0	0	0	75.7	0	0	12
2015	7	29	22	56	52	30	0	0	0	0	0	0	0	75.6	0	0	12
2015	7	29	23	6	52	30	0	0	0	0	0	0	0	75.49	0	0	12
2015	7	29	23	16	52	31	0	0	0	0	0	0	0	75.4	0	0	12
2015	7	29	23	26	52	31	0	0	0	0	0	0	0	75.29	0	0	12
2015	7	29	23	36	52	29	0	0	0	0	0	0	0	75.2	0	0	12
2015	7	29	23	46	52	30	0	0	0	0	0	0	0	75.11	0	0	12
2015	7	29	23	56	52	30	0	0	0	0	0	0	0	75	0	0	12
2015	7	30	0	6	52	30	0	0	0	0	0	0	0	74.89	0	0	12
2015	7	30	0	16	52	31	0	0	0	0	0	0	0	74.77	0	0	12
2015	7	30	0	26	52	30	0	0	0	0	0	0	0	74.68	0	0	12
2015	7	30	0	36	52	30	0	0	0	0	0	0	0	74.57	0	0	12
2015	7	30	0	46	52	30	0	0	0	0	0	0	0	74.46	0	0	12
2015	7	30	0	56	52	30	0	0	0	0	0	0	0	74.37	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	30	1	6	52	30	0	0	0	0	0	0	0	74.28	0	0	12
2015	7	30	1	16	52	31	0	0	0	0	0	0	0	74.17	0	0	12
2015	7	30	1	26	52	30	0	0	0	0	0	0	0	74.1	0	0	12
2015	7	30	1	36	52	31	0	0	0	0	0	0	0	74.03	0	0	12
2015	7	30	1	46	52	30	0	0	0	0	0	0	0	73.96	0	0	12
2015	7	30	1	56	52	30	0	0	0	0	0	0	0	73.89	0	0	12
2015	7	30	2	6	52	30	0	0	0	0	0	0	0	73.83	0	0	12
2015	7	30	2	16	52	30	0	0	0	0	0	0	0	73.76	0	0	12
2015	7	30	2	26	52	30	0	0	0	0	0	0	0	73.67	0	0	12
2015	7	30	2	36	52	31	0	0	0	0	0	0	0	73.58	0	0	12
2015	7	30	2	46	52	30	0	0	0	0	0	0	0	73.51	0	0	12
2015	7	30	2	56	52	31	0	0	0	0	0	0	0	73.42	0	0	12
2015	7	30	3	6	52	31	0	0	0	0	0	0	0	73.31	0	0	12
2015	7	30	3	16	52	30	0	0	0	0	0	0	0	73.22	0	0	12
2015	7	30	3	26	52	30	0	0	0	0	0	0	0	73.13	0	0	12
2015	7	30	3	36	52	30	0	0	0	0	0	0	0	73.04	0	0	12
2015	7	30	3	46	52	31	0	0	0	0	0	0	0	72.95	0	0	12
2015	7	30	3	56	52	30	0	0	0	0	0	0	0	72.86	0	0	12
2015	7	30	4	6	52	30	0	0	0	0	0	0	0	72.77	0	0	12
2015	7	30	4	16	52	31	0	0	0	0	0	0	0	72.68	0	0	12
2015	7	30	4	26	52	30	0	0	0	0	0	0	0	72.59	0	0	12
2015	7	30	4	36	52	31	0	0	0	0	0	0	0	72.5	0	0	12
2015	7	30	4	46	52	31	0	0	0	0	0	0	0	72.41	0	0	12
2015	7	30	4	56	52	31	0	0	0	0	0	0	0	72.34	0	0	12
2015	7	30	5	6	52	30	0	0	0	0	0	0	0	72.25	0	0	12
2015	7	30	5	16	52	31	0	0	0	0	0	0	0	72.16	0	0	12
2015	7	30	5	26	52	31	0	0	0	0	0	0	0	72.07	0	0	12
2015	7	30	5	36	52	31	0	0	0	0	0	0	0	72	0	0	12
2015	7	30	5	46	52	31	0	0	0	0	0	0	0	71.91	0	0	12
2015	7	30	5	56	52	30	0	0	0	0	0	0	0	71.83	0	0	12
2015	7	30	6	6	52	30	0	0	0	0	0	0	0	71.74	0	0	12
2015	7	30	6	16	52	30	0	0	0	0	0	0	0	71.69	0	0	12
2015	7	30	6	26	52	30	0	0	0	0	0	0	0	71.62	0	0	12
2015	7	30	6	36	52	31	0	0	0	0	0	0	0	71.56	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	30	6	46	52	32	0	0	0	0	0	0	0	71.49	0	0	12
2015	7	30	6	56	52	31	0	0	0	0	0	0	0	71.44	0	0	12
2015	7	30	7	6	52	31	0	0	0	0	0	0	0	71.58	0	0	12.2
2015	7	30	7	16	52	30	0	0	0	0	0	0	0	71.64	0	0	12.4
2015	7	30	7	26	52	31	0	0	0	0	0	0	0	71.73	0	0	12.4
2015	7	30	7	36	52	30	0	0	0	0	0	0	0	71.49	0	0	12.2
2015	7	30	7	46	52	31	0	0	0	0	0	0	0	71.46	0	0	12.2
2015	7	30	7	56	52	31	0	0	0	0	0	0	0	71.55	0	0	12.4
2015	7	30	8	6	52	31	0	0	0	0	0	0	0	71.49	0	0	12.2
2015	7	30	8	16	52	30	0	0	0	0	0	0	0	71.51	0	0	12.2
2015	7	30	8	26	52	31	0	0	0	0	0	0	0	71.6	0	0	12.2
2015	7	30	8	36	52	31	0	0	0	0	0	0	0	71.6	0	0	12.2
2015	7	30	8	46	52	31	0	0	0	0	0	0	0	71.91	0	0	12.6
2015	7	30	8	56	52	31	0	0	0	0	0	0	0	72.19	0	0	13
2015	7	30	9	6	52	31	0	0	0	0	0	0	0	72.36	0	0	13
2015	7	30	9	16	52	30	0	0	0	0	0	0	0	72	0	0	12.6
2015	7	30	9	26	52	31	0	0	0	0	0	0	0	71.91	0	0	12.6
2015	7	30	9	36	52	31	0	0	0	0	0	0	0	72.16	0	0	12.8
2015	7	30	9	46	52	31	0	0	0	0	0	0	0	72.36	0	0	12.8
2015	7	30	9	56	52	31	0	0	0	0	0	0	0	72.45	0	0	12.8
2015	7	30	10	14	31	30	0	0	0	0	0	0	0	72.63	0	0	12.8
2015	7	30	10	24	31	31	0	0	0	0	0	0	0	72.54	0	0	12.8
2015	7	30	10	34	31	31	0	0	0	0	0	0	0	72.64	0	0	12.6
2015	7	30	10	44	31	31	0	0	0	0	0	0	0	73.27	0	0	13.4
2015	7	30	10	54	31	31	0	0	0	0	0	0	0	73.38	0	0	13.2
2015	7	30	11	4	31	30	0	0	0	0	0	0	0	73.85	0	0	13.4
2015	7	30	11	14	31	30	0	0	0	0	0	0	0	73.71	0	0	13.2
2015	7	30	11	24	31	30	0	0	0	0	0	0	0	73.78	0	0	13.2
2015	7	30	11	34	31	31	0	0	0	0	0	0	0	73.62	0	0	12.8
2015	7	30	11	44	31	30	0	0	0	0	0	0	0	73.71	0	0	13.2
2015	7	30	11	54	31	31	0	0	0	0	0	0	0	73.81	0	0	13.2
2015	7	30	12	4	31	30	0	0	0	0	0	0	0	73.92	0	0	13.2
2015	7	30	12	14	31	30	0	0	0	0	0	0	0	74.08	0	0	13.4
2015	7	30	12	24	31	30	0	0	0	0	0	0	0	74.17	0	0	12.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	30	12	34	31	31	0	0	0	0	0	0	0	74.28	0	0	12.8
2015	7	30	12	44	31	30	0	0	0	0	0	0	0	74.48	0	0	12.8
2015	7	30	12	54	31	30	0	0	0	0	0	0	0	74.57	0	0	12.8
2015	7	30	13	4	31	30	0	0	0	0	0	0	0	74.66	0	0	12.8
2015	7	30	13	14	31	30	0	0	0	0	0	0	0	74.88	0	0	13
2015	7	30	13	24	31	30	0	0	0	0	0	0	0	75.06	0	0	13
2015	7	30	13	34	31	30	0	0	0	0	0	0	0	75.22	0	0	13
2015	7	30	13	44	31	30	0	0	0	0	0	0	0	75.25	0	0	13
2015	7	30	13	54	31	31	0	0	0	0	0	0	0	75.29	0	0	13
2015	7	30	14	4	31	31	0	0	0	0	0	0	0	75.47	0	0	13
2015	7	30	14	14	31	31	0	0	0	0	0	0	0	75.78	0	0	13.2
2015	7	30	14	24	31	30	0	0	0	0	0	0	0	76.01	0	0	13.2
2015	7	30	14	34	31	31	0	0	0	0	0	0	0	76.12	0	0	12.8
2015	7	30	14	44	31	30	0	0	0	0	0	0	0	75.87	0	0	12.8
2015	7	30	14	54	31	30	0	0	0	0	0	0	0	75.85	0	0	12.8
2015	7	30	15	4	31	30	0	0	0	0	0	0	0	75.97	0	0	12.8
2015	7	30	15	14	31	30	0	0	0	0	0	0	0	76.12	0	0	12.8
2015	7	30	15	24	31	30	0	0	0	0	0	0	0	76.14	0	0	12.8
2015	7	30	15	34	31	30	0	0	0	0	0	0	0	76.17	0	0	12.6
2015	7	30	15	44	31	30	0	0	0	0	0	0	0	76.1	0	0	12.4
2015	7	30	15	54	31	30	0	0	0	0	0	0	0	76.06	0	0	12.4
2015	7	30	16	4	31	30	0	0	0	0	0	0	0	76.01	0	0	12.2
2015	7	30	16	14	31	30	0	0	0	0	0	0	0	75.92	0	0	12.2
2015	7	30	16	24	31	30	0	0	0	0	0	0	0	75.87	0	0	12.2
2015	7	30	16	34	31	30	0	0	0	0	0	0	0	75.81	0	0	12.2
2015	7	30	16	44	31	30	0	0	0	0	0	0	0	75.81	0	0	12.2
2015	7	30	16	54	31	30	0	0	0	0	0	0	0	75.81	0	0	12.2
2015	7	30	17	4	31	30	0	0	0	0	0	0	0	75.81	0	0	12.2
2015	7	30	17	14	31	31	0	0	0	0	0	0	0	75.78	0	0	12.2
2015	7	30	17	24	31	30	0	0	0	0	0	0	0	75.72	0	0	12.2
2015	7	30	17	34	31	30	0	0	0	0	0	0	0	75.67	0	0	12
2015	7	30	17	44	31	30	0	0	0	0	0	0	0	75.65	0	0	12.2
2015	7	30	17	54	31	30	0	0	0	0	0	0	0	75.63	0	0	12.2
2015	7	30	18	4	31	30	0	0	0	0	0	0	0	75.58	0	0	12.2

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	30	18	14	31	31	0	0	0	0	0	0	0	75.52	0	0	12
2015	7	30	18	24	31	30	0	0	0	0	0	0	0	75.51	0	0	12
2015	7	30	18	34	31	30	0	0	0	0	0	0	0	75.47	0	0	12
2015	7	30	18	44	31	30	0	0	0	0	0	0	0	75.43	0	0	12
2015	7	30	18	54	31	30	0	0	0	0	0	0	0	75.36	0	0	12
2015	7	30	19	4	31	31	0	0	0	0	0	0	0	75.27	0	0	12
2015	7	30	19	14	31	30	0	0	0	0	0	0	0	75.18	0	0	12
2015	7	30	19	24	31	30	0	0	0	0	0	0	0	75.09	0	0	12
2015	7	30	19	34	31	31	0	0	0	0	0	0	0	75	0	0	12
2015	7	30	19	44	31	31	0	0	0	0	0	0	0	74.91	0	0	12
2015	7	30	19	54	31	31	0	0	0	0	0	0	0	74.82	0	0	12
2015	7	30	20	4	31	30	0	0	0	0	0	0	0	74.75	0	0	12
2015	7	30	20	14	31	30	0	0	0	0	0	0	0	74.68	0	0	12
2015	7	30	20	24	31	30	0	0	0	0	0	0	0	74.61	0	0	12
2015	7	30	20	34	31	30	0	0	0	0	0	0	0	74.53	0	0	11.8
2015	7	30	20	44	31	30	0	0	0	0	0	0	0	74.44	0	0	12
2015	7	30	20	54	31	31	0	0	0	0	0	0	0	74.37	0	0	12
2015	7	30	21	4	31	31	0	0	0	0	0	0	0	74.28	0	0	12
2015	7	30	21	14	31	31	0	0	0	0	0	0	0	74.21	0	0	12
2015	7	30	21	24	31	30	0	0	0	0	0	0	0	74.12	0	0	12
2015	7	30	21	34	31	30	0	0	0	0	0	0	0	74.05	0	0	12
2015	7	30	21	44	31	30	0	0	0	0	0	0	0	73.96	0	0	12
2015	7	30	21	54	31	30	0	0	0	0	0	0	0	73.87	0	0	12
2015	7	30	22	4	31	32	0	0	0	0	0	0	0	73.78	0	0	12
2015	7	30	22	14	31	30	0	0	0	0	0	0	0	73.69	0	0	12
2015	7	30	22	24	31	30	0	0	0	0	0	0	0	73.6	0	0	12
2015	7	30	22	34	31	31	0	0	0	0	0	0	0	73.51	0	0	11.8
2015	7	30	22	44	31	30	0	0	0	0	0	0	0	73.44	0	0	12
2015	7	30	22	54	31	31	0	0	0	0	0	0	0	73.36	0	0	12
2015	7	30	23	4	31	30	0	0	0	0	0	0	0	73.29	0	0	12
2015	7	30	23	14	31	30	0	0	0	0	0	0	0	73.22	0	0	12
2015	7	30	23	24	31	31	0	0	0	0	0	0	0	73.15	0	0	12
2015	7	30	23	34	31	31	0	0	0	0	0	0	0	73.08	0	0	11.8
2015	7	30	23	44	31	30	0	0	0	0	0	0	0	72.99	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	30	23	54	31	31	0	0	0	0	0	0	0	72.88	0	0	12
2015	7	31	0	4	31	30	0	0	0	0	0	0	0	72.77	0	0	12
2015	7	31	0	14	31	30	0	0	0	0	0	0	0	72.68	0	0	12
2015	7	31	0	24	31	30	0	0	0	0	0	0	0	72.57	0	0	12
2015	7	31	0	34	31	31	0	0	0	0	0	0	0	72.46	0	0	11.8
2015	7	31	0	44	31	30	0	0	0	0	0	0	0	72.36	0	0	12
2015	7	31	0	54	31	31	0	0	0	0	0	0	0	72.27	0	0	12
2015	7	31	1	4	31	31	0	0	0	0	0	0	0	72.18	0	0	12
2015	7	31	1	14	31	30	0	0	0	0	0	0	0	72.1	0	0	12
2015	7	31	1	24	31	31	0	0	0	0	0	0	0	72.03	0	0	12
2015	7	31	1	34	31	30	0	0	0	0	0	0	0	71.96	0	0	11.8
2015	7	31	1	44	31	31	0	0	0	0	0	0	0	71.89	0	0	12
2015	7	31	1	54	31	31	0	0	0	0	0	0	0	71.8	0	0	12
2015	7	31	2	4	31	30	0	0	0	0	0	0	0	71.73	0	0	12
2015	7	31	2	14	31	31	0	0	0	0	0	0	0	71.64	0	0	12
2015	7	31	2	24	31	30	0	0	0	0	0	0	0	71.53	0	0	12
2015	7	31	2	34	31	31	0	0	0	0	0	0	0	71.44	0	0	11.8
2015	7	31	2	44	31	31	0	0	0	0	0	0	0	71.35	0	0	12
2015	7	31	2	54	31	31	0	0	0	0	0	0	0	71.26	0	0	11.8
2015	7	31	3	4	31	31	0	0	0	0	0	0	0	71.19	0	0	11.8
2015	7	31	3	14	31	30	0	0	0	0	0	0	0	71.13	0	0	11.8
2015	7	31	3	24	31	30	0	0	0	0	0	0	0	71.06	0	0	11.8
2015	7	31	3	34	31	31	0	0	0	0	0	0	0	71.01	0	0	11.8
2015	7	31	3	44	31	31	0	0	0	0	0	0	0	70.97	0	0	11.8
2015	7	31	3	54	31	32	0	0	0	0	0	0	0	70.92	0	0	11.8
2015	7	31	4	4	31	31	0	0	0	0	0	0	0	70.84	0	0	11.8
2015	7	31	4	14	31	31	0	0	0	0	0	0	0	70.81	0	0	11.8
2015	7	31	4	24	31	31	0	0	0	0	0	0	0	70.75	0	0	11.8
2015	7	31	4	34	31	30	0	0	0	0	0	0	0	70.7	0	0	11.8
2015	7	31	4	44	31	30	0	0	0	0	0	0	0	70.65	0	0	11.8
2015	7	31	4	54	31	30	0	0	0	0	0	0	0	70.61	0	0	11.8
2015	7	31	5	4	31	31	0	0	0	0	0	0	0	70.57	0	0	11.8
2015	7	31	5	14	31	31	0	0	0	0	0	0	0	70.52	0	0	11.8
2015	7	31	5	24	31	31	0	0	0	0	0	0	0	70.48	0	0	11.8

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	31	5	34	31	31	0	0	0	0	0	0	0	70.45	0	0	11.8
2015	7	31	5	44	31	31	0	0	0	0	0	0	0	70.43	0	0	11.8
2015	7	31	5	54	31	31	0	0	0	0	0	0	0	70.41	0	0	11.8
2015	7	31	6	4	31	31	0	0	0	0	0	0	0	70.38	0	0	11.8
2015	7	31	6	14	31	31	0	0	0	0	0	0	0	70.34	0	0	11.8
2015	7	31	6	24	31	31	0	0	0	0	0	0	0	70.32	0	0	11.8
2015	7	31	6	34	31	31	0	0	0	0	0	0	0	70.3	0	0	11.8
2015	7	31	6	44	31	31	0	0	0	0	0	0	0	70.29	0	0	11.8
2015	7	31	6	54	31	30	0	0	0	0	0	0	0	70.23	0	0	11.8
2015	7	31	7	4	31	31	0	0	0	0	0	0	0	70.21	0	0	11.8
2015	7	31	7	14	31	31	0	0	0	0	0	0	0	70.16	0	0	12
2015	7	31	7	24	31	31	0	0	0	0	0	0	0	70.12	0	0	12
2015	7	31	7	34	31	31	0	0	0	0	0	0	0	70.09	0	0	11.8
2015	7	31	7	44	31	31	0	0	0	0	0	0	0	70.03	0	0	12
2015	7	31	7	54	31	31	0	0	0	0	0	0	0	70.02	0	0	12
2015	7	31	8	4	31	31	0	0	0	0	0	0	0	69.96	0	0	12
2015	7	31	8	14	31	31	0	0	0	0	0	0	0	69.93	0	0	12
2015	7	31	8	24	31	31	0	0	0	0	0	0	0	69.89	0	0	12
2015	7	31	8	34	31	31	0	0	0	0	0	0	0	69.87	0	0	11.8
2015	7	31	8	44	31	31	0	0	0	0	0	0	0	69.85	0	0	12
2015	7	31	8	54	31	31	0	0	0	0	0	0	0	69.82	0	0	12
2015	7	31	9	4	31	31	0	0	0	0	0	0	0	69.78	0	0	12
2015	7	31	9	14	31	31	0	0	0	0	0	0	0	69.75	0	0	12
2015	7	31	9	24	31	31	0	0	0	0	0	0	0	69.75	0	0	12
2015	7	31	9	34	31	31	0	0	0	0	0	0	0	69.76	0	0	12
2015	7	31	9	44	31	31	0	0	0	0	0	0	0	69.8	0	0	12
2015	7	31	9	54	31	32	0	0	0	0	0	0	0	69.82	0	0	12.2
2015	7	31	10	4	31	31	0	0	0	0	0	0	0	69.91	0	0	12.2
2015	7	31	10	14	31	31	0	0	0	0	0	0	0	69.93	0	0	12.2
2015	7	31	10	24	31	30	0	0	0	0	0	0	0	69.93	0	0	12.4
2015	7	31	10	34	31	31	0	0	0	0	0	0	0	69.93	0	0	12.2
2015	7	31	10	44	31	32	0	0	0	0	0	0	0	69.91	0	0	12.2
2015	7	31	10	54	31	31	0	0	0	0	0	0	0	70.03	0	0	12.4
2015	7	31	11	4	31	31	0	0	0	0	0	0	0	70.21	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	31	11	14	31	31	0	0	0	0	0	0	0	70.23	0	0	12.4
2015	7	31	11	24	31	31	0	0	0	0	0	0	0	70.12	0	0	12.4
2015	7	31	11	34	31	31	0	0	0	0	0	0	0	70.2	0	0	12.2
2015	7	31	11	44	31	31	0	0	0	0	0	0	0	70.14	0	0	12.2
2015	7	31	11	54	31	30	0	0	0	0	0	0	0	70.12	0	0	12.4
2015	7	31	12	4	31	31	0	0	0	0	0	0	0	70.14	0	0	12.4
2015	7	31	12	14	31	30	0	0	0	0	0	0	0	70.23	0	0	12.4
2015	7	31	12	24	31	30	0	0	0	0	0	0	0	70.39	0	0	12.6
2015	7	31	12	34	31	31	0	0	0	0	0	0	0	70.43	0	0	12.4
2015	7	31	12	44	31	30	0	0	0	0	0	0	0	70.45	0	0	12.6
2015	7	31	12	54	31	31	0	0	0	0	0	0	0	70.61	0	0	12.6
2015	7	31	13	4	31	30	0	0	0	0	0	0	0	70.61	0	0	12.6
2015	7	31	13	14	31	30	0	0	0	0	0	0	0	70.72	0	0	12.8
2015	7	31	13	24	31	31	0	0	0	0	0	0	0	70.81	0	0	12.8
2015	7	31	13	34	31	31	0	0	0	0	0	0	0	70.83	0	0	12.6
2015	7	31	13	44	31	30	0	0	0	0	0	0	0	70.9	0	0	12.8
2015	7	31	13	54	31	31	0	0	0	0	0	0	0	71.1	0	0	12.8
2015	7	31	14	4	31	31	0	0	0	0	0	0	0	71.28	0	0	13
2015	7	31	14	14	31	30	0	0	0	0	0	0	0	71.51	0	0	13
2015	7	31	14	24	31	31	0	0	0	0	0	0	0	71.38	0	0	12.8
2015	7	31	14	34	31	31	0	0	0	0	0	0	0	71.73	0	0	13
2015	7	31	14	44	31	30	0	0	0	0	0	0	0	71.65	0	0	12.8
2015	7	31	14	54	31	31	0	0	0	0	0	0	0	71.8	0	0	12.8
2015	7	31	15	4	31	31	0	0	0	0	0	0	0	71.69	0	0	12.6
2015	7	31	15	14	31	31	0	0	0	0	0	0	0	72.28	0	0	13
2015	7	31	15	24	31	31	0	0	0	0	0	0	0	72.46	0	0	13
2015	7	31	15	34	31	31	0	0	0	0	0	0	0	72.57	0	0	12.8
2015	7	31	15	44	31	30	0	0	0	0	0	0	0	72.75	0	0	13
2015	7	31	15	54	31	30	0	0	0	0	0	0	0	72.91	0	0	13
2015	7	31	16	4	31	31	0	0	0	0	0	0	0	72.81	0	0	12.8
2015	7	31	16	14	31	31	0	0	0	0	0	0	0	73.09	0	0	12.8
2015	7	31	16	24	31	30	0	0	0	0	0	0	0	73.13	0	0	12.6
2015	7	31	16	34	31	31	0	0	0	0	0	0	0	73.13	0	0	12.4
2015	7	31	16	44	31	31	0	0	0	0	0	0	0	73.15	0	0	12.4

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	31	16	54	31	31	0	0	0	0	0	0	0	73.15	0	0	12.4
2015	7	31	17	4	31	31	0	0	0	0	0	0	0	73.04	0	0	12.4
2015	7	31	17	14	31	31	0	0	0	0	0	0	0	73	0	0	12.4
2015	7	31	17	24	31	31	0	0	0	0	0	0	0	73.02	0	0	12.4
2015	7	31	17	34	31	30	0	0	0	0	0	0	0	73.04	0	0	12.2
2015	7	31	17	44	31	30	0	0	0	0	0	0	0	73.06	0	0	12.2
2015	7	31	17	54	31	31	0	0	0	0	0	0	0	73.06	0	0	12.2
2015	7	31	18	4	31	31	0	0	0	0	0	0	0	73.06	0	0	12.2
2015	7	31	18	14	31	31	0	0	0	0	0	0	0	73.09	0	0	12.2
2015	7	31	18	24	31	30	0	0	0	0	0	0	0	73.11	0	0	12.2
2015	7	31	18	34	31	30	0	0	0	0	0	0	0	73.13	0	0	12.2
2015	7	31	18	44	31	30	0	0	0	0	0	0	0	73.15	0	0	12.2
2015	7	31	18	54	31	31	0	0	0	0	0	0	0	73.17	0	0	12.2
2015	7	31	19	4	31	30	0	0	0	0	0	0	0	73.18	0	0	12.2
2015	7	31	19	14	31	30	0	0	0	0	0	0	0	73.2	0	0	12.2
2015	7	31	19	24	31	30	0	0	0	0	0	0	0	73.22	0	0	12.2
2015	7	31	19	34	31	31	0	0	0	0	0	0	0	73.24	0	0	12
2015	7	31	19	44	31	31	0	0	0	0	0	0	0	73.24	0	0	12
2015	7	31	19	54	31	30	0	0	0	0	0	0	0	73.26	0	0	12
2015	7	31	20	4	31	31	0	0	0	0	0	0	0	73.26	0	0	12
2015	7	31	20	14	31	31	0	0	0	0	0	0	0	73.27	0	0	12
2015	7	31	20	24	31	31	0	0	0	0	0	0	0	73.29	0	0	12
2015	7	31	20	34	31	30	0	0	0	0	0	0	0	73.29	0	0	12
2015	7	31	20	44	31	30	0	0	0	0	0	0	0	73.29	0	0	12
2015	7	31	20	54	31	31	0	0	0	0	0	0	0	73.27	0	0	12
2015	7	31	21	4	31	30	0	0	0	0	0	0	0	73.26	0	0	12
2015	7	31	21	14	31	30	0	0	0	0	0	0	0	73.22	0	0	12
2015	7	31	21	24	31	30	0	0	0	0	0	0	0	73.18	0	0	12
2015	7	31	21	34	31	31	0	0	0	0	0	0	0	73.15	0	0	12
2015	7	31	21	44	31	30	0	0	0	0	0	0	0	73.09	0	0	12
2015	7	31	21	54	31	31	0	0	0	0	0	0	0	73.04	0	0	12
2015	7	31	22	4	31	31	0	0	0	0	0	0	0	72.99	0	0	12
2015	7	31	22	14	31	30	0	0	0	0	0	0	0	72.91	0	0	12
2015	7	31	22	24	31	30	0	0	0	0	0	0	0	72.88	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	31	22	34	31	31	0	0	0	0	0	0	0	72.81	0	0	11.8
2015	7	31	22	44	31	31	0	0	0	0	0	0	0	72.75	0	0	12
2015	7	31	22	54	31	30	0	0	0	0	0	0	0	72.7	0	0	12
2015	7	31	23	4	31	31	0	0	0	0	0	0	0	72.63	0	0	12
2015	7	31	23	14	31	30	0	0	0	0	0	0	0	72.57	0	0	12
2015	7	31	23	24	31	31	0	0	0	0	0	0	0	72.54	0	0	12
2015	7	31	23	34	31	30	0	0	0	0	0	0	0	72.48	0	0	11.8
2015	7	31	23	44	31	31	0	0	0	0	0	0	0	72.43	0	0	12
2015	7	31	23	54	31	31	0	0	0	0	0	0	0	72.39	0	0	12

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	1	0	6	52	0.3	1	0.32	88.2	6.7962	1.9395
2015	7	1	0	16	52	0.3	1	0.23	101.3	6.7768	1.3811
2015	7	1	0	26	52	0.3	1	0.21	97.1	6.7574	1.2589
2015	7	1	0	36	52	0.3	1	0.21	78.5	6.7381	1.255
2015	7	1	0	46	52	0.3	1	0.32	87.7	6.7187	1.9158
2015	7	1	0	56	52	0.3	1	0.22	103.2	6.7187	1.2512
2015	7	1	1	6	52	0.3	1	0.18	106.1	6.6994	1.0134
2015	7	1	1	16	52	0.3	1	0.2	99.3	6.6994	1.1888
2015	7	1	1	26	52	0.3	1	0.24	93.9	6.6994	1.4422
2015	7	1	1	36	52	0.3	1	0.26	91.4	6.68	1.5543
2015	7	1	1	46	52	0.3	1	0.2	82.3	6.68	1.1463
2015	7	1	1	56	52	0.3	1	0.25	100.6	6.68	1.4571
2015	7	1	2	6	52	0.3	1	0.19	96	6.6607	1.104
2015	7	1	2	16	52	0.3	1	0.21	87.3	6.6607	1.2202
2015	7	1	2	26	52	0.3	1	0.19	107.2	6.6607	1.0653
2015	7	1	2	36	52	0.3	1	0.24	89.2	6.6607	1.4333
2015	7	1	2	46	52	0.3	1	0.2	106.6	6.6413	1.1006
2015	7	1	2	56	52	0.3	1	0.21	103.4	6.6413	1.2164
2015	7	1	3	6	52	0.3	1	0.17	95.6	6.6413	0.9847
2015	7	1	3	16	52	0.3	1	0.24	103.5	6.6413	1.3709
2015	7	1	3	26	52	0.3	1	0.22	76	6.6219	1.2319
2015	7	1	3	36	52	0.3	1	0.24	69.8	6.6219	1.3088
2015	7	1	3	46	52	0.3	1	0.17	102.2	6.6219	0.9816
2015	7	1	3	56	52	0.3	1	0.16	97	6.6219	0.9431
2015	7	1	4	6	52	0.3	1	0.22	95	6.6026	1.3048
2015	7	1	4	16	52	0.3	1	0.18	92.1	6.6026	1.0553
2015	7	1	4	26	52	0.3	1	0.2	119.1	6.5832	0.9946
2015	7	1	4	36	52	0.3	1	0.14	118.4	6.5832	0.7077
2015	7	1	4	46	52	0.3	1	0.23	80.9	6.5639	1.3156
2015	7	1	4	56	52	0.3	1	0.21	111.8	6.5639	1.144
2015	7	1	5	6	52	0.3	1	0.18	85.9	6.5445	1.0644
2015	7	1	5	16	52	0.3	1	0.13	90	6.5252	0.7389
2015	7	1	5	26	52	0.3	1	0.2	103.6	6.5058	1.0954
2015	7	1	5	36	52	0.3	1	0.1	123.2	6.4864	0.4895

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	1	5	46	52	0.3	1	0.07	58.6	6.4671	0.3378
2015	7	1	5	56	52	0.3	1	0.16	99.3	6.4671	0.9195
2015	7	1	6	6	52	0.3	1	0.22	86.6	6.4284	1.2492
2015	7	1	6	16	52	0.3	1	0.21	78.5	6.4284	1.1933
2015	7	1	6	26	52	0.3	1	0.16	63.9	6.409	0.8363
2015	7	1	6	36	52	0.3	1	0.2	60.9	6.4284	1.0068
2015	7	1	6	46	52	0.3	1	0.23	49	6.4284	0.9882
2015	7	1	6	56	52	0.3	1	0.25	55.7	6.4284	1.1746
2015	7	1	7	6	52	0.3	1	0.25	64.1	6.409	1.2638
2015	7	1	7	16	52	0.3	1	0.26	50.7	6.409	1.1337
2015	7	1	7	26	52	0.3	1	0.24	42.8	6.409	0.9292
2015	7	1	7	36	52	0.3	1	0.24	45	6.409	0.9478
2015	7	1	7	46	52	0.3	1	0.19	72.2	6.3897	1.0374
2015	7	1	7	56	52	0.3	1	0.25	40.3	6.3897	0.9262
2015	7	1	8	6	52	0.3	1	0.19	49.2	6.3897	0.8151
2015	7	1	8	16	52	0.3	1	0.28	62.2	6.3897	1.4079
2015	7	1	8	26	52	0.3	1	0.28	50.7	6.3703	1.2187
2015	7	1	8	36	52	0.3	1	0.25	65.4	6.3703	1.2925
2015	7	1	8	46	52	0.3	1	0.27	40.1	6.3703	0.9786
2015	7	1	8	56	52	0.3	1	0.2	42.3	6.3509	0.7546
2015	7	1	9	6	52	0.3	1	0.23	39.3	6.3509	0.8282
2015	7	1	9	16	52	0.3	1	0.21	31.3	6.3316	0.6237
2015	7	1	9	26	52	0.3	1	0.26	38.9	6.3316	0.9172
2015	7	1	9	36	52	0.3	1	0.31	41.1	6.3122	1.1336
2015	7	1	9	46	52	0.3	1	0.29	49.1	6.3122	1.225
2015	7	1	9	56	52	0.3	1	0.28	40.7	6.2929	1.0205
2015	7	1	10	6	52	0.3	1	0.22	39.1	6.2542	0.7784
2015	7	1	10	16	52	0.3	1	0.4	31.9	6.2542	1.1586
2015	7	1	10	26	52	0.3	1	0.26	31.1	6.2348	0.7398
2015	7	1	10	36	52	0.3	1	0.35	35.3	6.2154	1.097
2015	7	1	10	46	52	0.3	1	0.33	48.3	6.2154	1.3307
2015	7	1	10	56	52	0.3	1	0.35	36.5	6.2154	1.1329
2015	7	1	11	6	52	0.3	1	0.28	36.1	6.1961	0.9141
2015	7	1	11	16	52	0.3	1	0.23	45	6.1961	0.8782

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	1	11	26	52	0.3	1	0.36	43.1	6.1961	1.3263
2015	7	1	11	36	52	0.3	1	0.29	39.6	6.1961	1.0216
2015	7	1	11	46	52	0.3	1	0.25	46.1	6.1961	0.9857
2015	7	1	11	56	52	0.3	1	0.23	45.6	6.1961	0.9141
2015	7	1	12	6	52	0.3	1	0.32	52.2	6.1961	1.3621
2015	7	1	12	16	52	0.3	1	0.28	58.9	6.1767	1.304
2015	7	1	12	26	52	0.3	1	0.3	43.7	6.1767	1.1432
2015	7	1	12	36	52	0.3	1	0.25	36.6	6.1767	0.8217
2015	7	1	12	46	52	0.3	1	0.22	48.1	6.1767	0.8753
2015	7	1	12	56	52	0.3	1	0.26	50.6	6.1767	1.1075
2015	7	1	13	6	52	0.3	1	0.26	28.2	6.1767	0.6609
2015	7	1	13	16	52	0.3	1	0.25	66.1	6.1767	1.2504
2015	7	1	13	26	52	0.3	1	0.26	48.1	6.1767	1.036
2015	7	1	13	36	52	0.3	1	0.26	49.2	6.1767	1.0539
2015	7	1	13	46	52	0.3	1	0.29	60.8	6.1961	1.38
2015	7	1	13	56	52	0.3	1	0.23	61.3	6.1767	1.1074
2015	7	1	14	6	52	0.3	1	0.27	55.9	6.1767	1.2146
2015	7	1	14	16	52	0.3	1	0.15	61.2	6.1961	0.7169
2015	7	1	14	26	52	0.3	1	0.17	84.4	6.1961	0.914
2015	7	1	14	36	52	0.3	1	0.18	53.7	6.1767	0.8038
2015	7	1	14	46	52	0.3	1	0.2	41.6	6.1961	0.7169
2015	7	1	14	56	52	0.3	1	0.23	59.3	6.1961	1.0574
2015	7	1	15	6	52	0.3	1	0.19	74.3	6.1961	1.0215
2015	7	1	15	16	52	0.3	1	0.2	59.7	6.1961	0.9498
2015	7	1	15	26	52	0.3	1	0.16	37.6	6.1767	0.5358
2015	7	1	15	36	52	0.3	1	0.25	38.7	6.1961	0.8602
2015	7	1	15	46	52	0.3	1	0.2	67.7	6.1767	1.0002
2015	7	1	15	56	52	0.3	1	0.23	64.5	6.1961	1.1291
2015	7	1	16	6	52	0.3	1	0.18	76.2	6.1767	0.9467
2015	7	1	16	16	52	0.3	1	0.2	78.7	6.1767	1.0717
2015	7	1	16	26	52	0.3	1	0.14	83.2	6.1767	0.7502
2015	7	1	16	36	52	0.3	1	0.13	48	6.1961	0.5376
2015	7	1	16	46	52	0.3	1	0.21	74.4	6.1767	1.0895
2015	7	1	16	56	52	0.3	1	0.15	72	6.1961	0.7706

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	1	17	6	52	0.3	1	0.19	79.9	6.1961	1.0036
2015	7	1	17	16	52	0.3	1	0.17	86.6	6.1961	0.914
2015	7	1	17	26	52	0.3	1	0.24	75.6	6.1961	1.2545
2015	7	1	17	36	52	0.3	1	0.18	70.9	6.1767	0.9288
2015	7	1	17	46	52	0.3	1	0.18	93.2	6.1767	0.9645
2015	7	1	17	56	52	0.3	1	0.13	82.5	6.1767	0.6787
2015	7	1	18	6	52	0.3	1	0.19	107.2	6.1767	0.9824
2015	7	1	18	16	52	0.3	1	0.16	47.5	6.1767	0.643
2015	7	1	18	26	52	0.3	1	0.09	83.9	6.1767	0.5001
2015	7	1	18	36	52	0.3	1	0.12	64.8	6.1767	0.6073
2015	7	1	18	46	52	0.3	1	0.18	77	6.1767	0.9288
2015	7	1	18	56	52	0.3	1	0.13	90	6.1767	0.7323
2015	7	1	19	6	52	0.3	1	0.2	86.3	6.1767	1.1074
2015	7	1	19	16	52	0.3	1	0.1	68.6	6.1767	0.5001
2015	7	1	19	26	52	0.3	1	0.14	88.6	6.1767	0.7502
2015	7	1	19	36	52	0.3	1	0.19	88	6.1767	1.0181
2015	7	1	19	46	52	0.3	1	0.16	110.3	6.1767	0.8216
2015	7	1	19	56	52	0.3	1	0.12	91.5	6.1767	0.6609
2015	7	1	20	6	52	0.3	1	0.06	45	6.1767	0.2143
2015	7	1	20	16	52	0.3	1	0.09	62.5	6.1574	0.445
2015	7	1	20	26	52	0.3	1	0.12	71.6	6.1574	0.6408
2015	7	1	20	36	52	0.3	1	0.13	48.1	6.1574	0.5162
2015	7	1	20	46	52	0.3	1	0.14	59.7	6.1574	0.6408
2015	7	1	20	56	52	0.3	1	0.11	58.7	6.1574	0.4984
2015	7	1	21	6	52	0.3	1	0.09	83.9	6.1574	0.4984
2015	7	1	21	16	52	0.3	1	0.16	94.6	6.1574	0.8901
2015	7	1	21	26	52	0.3	1	0.15	90	6.1574	0.8011
2015	7	1	21	36	52	0.3	1	0.06	101.9	6.1574	0.3382
2015	7	1	21	46	52	0.3	1	0.18	84.8	6.1574	0.9791
2015	7	1	21	56	52	0.3	1	0.17	83.3	6.1574	0.9079
2015	7	1	22	6	52	0.3	1	0.15	110.4	6.1574	0.7655
2015	7	1	22	16	52	0.3	1	0.15	90	6.1574	0.8011
2015	7	1	22	26	52	0.3	1	0.09	105.1	6.138	0.4613
2015	7	1	22	36	52	0.3	1	0.11	78.4	6.138	0.6032

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	1	22	46	52	0.3	1	0.18	99.6	6.138	0.9403
2015	7	1	22	56	52	0.3	1	0.21	112.1	6.138	1.0467
2015	7	1	23	6	52	0.3	1	0.13	101.6	6.138	0.6919
2015	7	1	23	16	52	0.3	1	0.1	101	6.138	0.55
2015	7	1	23	26	52	0.3	1	0.13	76.7	6.138	0.6742
2015	7	1	23	36	52	0.3	1	0.12	108.9	6.138	0.6209
2015	7	1	23	46	52	0.3	1	0.11	121.3	6.138	0.4968
2015	7	1	23	56	52	0.3	1	0.08	65.6	6.1187	0.389
2015	7	2	0	6	52	0.3	1	0.14	107.2	6.1187	0.7426
2015	7	2	0	16	52	0.3	1	0.23	62.4	6.0993	1.1101
2015	7	2	0	26	52	0.3	1	0.13	62.2	6.0993	0.6344
2015	7	2	0	36	52	0.3	1	0.16	54.1	6.0993	0.7048
2015	7	2	0	46	52	0.3	1	0.2	66.4	6.08	0.9659
2015	7	2	0	56	52	0.3	1	0.19	60.3	6.0606	0.8575
2015	7	2	1	6	52	0.3	1	0.13	34.9	6.08	0.4039
2015	7	2	1	16	52	0.3	1	0.13	53.4	6.08	0.5444
2015	7	2	1	26	52	0.3	1	0.19	85.2	6.08	1.0361
2015	7	2	1	36	52	0.3	1	0.14	67.2	6.08	0.6673
2015	7	2	1	46	52	0.3	1	0.19	54.7	6.0606	0.84
2015	7	2	1	56	52	0.3	1	0.16	75.4	6.0606	0.805
2015	7	2	2	6	52	0.3	1	0.19	36.7	6.0993	0.6167
2015	7	2	2	16	52	0.3	1	0.15	27.1	6.0219	0.365
2015	7	2	2	26	52	0.3	1	0.24	30	6.0993	0.652
2015	7	2	2	36	52	0.3	1	0.23	57.7	6.0993	1.0573
2015	7	2	2	46	52	0.3	1	0.21	69.9	6.08	1.0537
2015	7	2	2	56	52	0.3	1	0.14	51.5	6.0606	0.595
2015	7	2	3	6	52	0.3	1	0.14	67	6.08	0.7025
2015	7	2	3	16	52	0.3	1	0.25	54	6.0993	1.0925
2015	7	2	3	26	52	0.3	1	0.16	45	6.08	0.5971
2015	7	2	3	36	52	0.3	1	0.3	48.1	6.1187	1.2023
2015	7	2	3	46	52	0.3	1	0.2	47.7	6.1187	0.778
2015	7	2	3	56	52	0.3	1	0.19	48.5	6.0993	0.7577
2015	7	2	4	6	52	0.3	1	0.18	45	6.1187	0.6719
2015	7	2	4	16	52	0.3	1	0.16	37.3	6.1187	0.5128

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	2	4	26	52	0.3	1	0.22	42.6	6.1187	0.8134
2015	7	2	4	36	52	0.3	1	0.24	46.7	6.1187	0.9371
2015	7	2	4	46	52	0.3	1	0.24	43.4	6.1187	0.9018
2015	7	2	4	56	52	0.3	1	0.23	39.8	6.1187	0.7957
2015	7	2	5	6	52	0.3	1	0.18	37.7	6.1187	0.6012
2015	7	2	5	16	52	0.3	1	0.18	45.7	6.1187	0.6896
2015	7	2	5	26	52	0.3	1	0.24	38.3	6.1187	0.7957
2015	7	2	5	36	52	0.3	1	0.13	37.7	6.1187	0.4244
2015	7	2	5	46	52	0.3	1	0.23	49.7	6.138	0.9403
2015	7	2	5	56	52	0.3	1	0.28	38.3	6.138	0.9403
2015	7	2	6	6	52	0.3	1	0.23	51.8	6.1187	0.9902
2015	7	2	6	16	52	0.3	1	0.34	50.6	6.1187	1.3969
2015	7	2	6	26	52	0.3	1	0.27	48.9	6.1187	1.0963
2015	7	2	6	36	52	0.3	1	0.26	54.7	6.1187	1.1493
2015	7	2	6	46	52	0.3	1	0.26	35.3	6.1187	0.8134
2015	7	2	6	56	52	0.3	1	0.29	32.4	6.1187	0.831
2015	7	2	7	6	52	0.3	1	0.29	19	6.1187	0.5128
2015	7	2	7	16	52	0.3	1	0.25	30.6	6.1187	0.6896
2015	7	2	7	26	52	0.3	1	0.3	42.8	6.1187	1.114
2015	7	2	7	36	52	0.3	1	0.19	36.7	6.1187	0.6189
2015	7	2	7	46	52	0.3	1	0.32	40	6.1187	1.0963
2015	7	2	7	56	52	0.3	1	0.21	29.7	6.0993	0.5639
2015	7	2	8	6	52	0.3	1	0.26	36.1	6.0993	0.8106
2015	7	2	8	16	52	0.3	1	0.27	43.5	6.0993	1.0044
2015	7	2	8	26	52	0.3	1	0.25	33.1	6.08	0.72
2015	7	2	8	36	52	0.3	1	0.19	52.9	6.08	0.7903
2015	7	2	8	46	52	0.3	1	0.22	23.9	6.08	0.4742
2015	7	2	8	56	52	0.3	1	0.23	51.8	6.0606	0.9801
2015	7	2	9	6	52	0.3	1	0.21	45.6	6.0606	0.7876
2015	7	2	9	16	52	0.3	1	0.21	51.9	6.0412	0.8895
2015	7	2	9	26	52	0.3	1	0.18	62.5	6.0412	0.8721
2015	7	2	9	36	52	0.3	1	0.21	55.8	6.0219	0.9212
2015	7	2	9	46	52	0.3	1	0.21	37.4	6.0219	0.6779
2015	7	2	9	56	52	0.3	1	0.16	54.3	6.0219	0.6779

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	2	10	6	52	0.3	1	0.24	57.4	6.0219	1.0603
2015	7	2	10	16	52	0.3	1	0.22	49.9	6.0219	0.8864
2015	7	2	10	26	52	0.3	1	0.15	82.6	6.0412	0.8023
2015	7	2	10	36	52	0.3	1	0.15	43.2	6.0412	0.5407
2015	7	2	10	46	52	0.3	1	0.16	54.3	6.0412	0.6802
2015	7	2	10	56	52	0.3	1	0.18	57.4	6.0412	0.8197
2015	7	2	11	6	52	0.3	1	0.12	97.7	6.0412	0.6453
2015	7	2	11	16	52	0.3	1	0.17	83.4	6.0606	0.9101
2015	7	2	11	26	52	0.3	1	0.12	94.6	6.0606	0.6475
2015	7	2	11	36	52	0.3	1	0.09	63.4	6.08	0.4215
2015	7	2	11	46	52	0.3	1	0.08	70	6.08	0.3864
2015	7	2	11	56	52	0.3	1	0.2	64.3	6.08	0.9834
2015	7	2	12	6	52	0.3	1	0.17	70.9	6.0993	0.8634
2015	7	2	12	16	52	0.3	1	0.1	80.5	6.0993	0.5286
2015	7	2	12	26	52	0.3	1	0.12	115.1	6.1187	0.5658
2015	7	2	12	36	52	0.3	1	0.18	84.8	6.1187	0.9725
2015	7	2	12	46	52	0.3	1	0.16	52.4	6.1187	0.6896
2015	7	2	12	56	52	0.3	1	0.18	57.8	6.1187	0.8133
2015	7	2	13	6	52	0.3	1	0.2	42.4	6.138	0.7451
2015	7	2	13	16	52	0.3	1	0.15	37.6	6.138	0.479
2015	7	2	13	26	52	0.3	1	0.15	55.6	6.138	0.6742
2015	7	2	13	36	52	0.3	1	0.19	67.1	6.138	0.9225
2015	7	2	13	46	52	0.3	1	0.14	76.3	6.1574	0.7298
2015	7	2	13	56	52	0.3	1	0.18	73.2	6.1574	0.9435
2015	7	2	14	6	52	0.3	1	0.18	83.7	6.1574	0.9613
2015	7	2	14	16	52	0.3	1	0.15	97.6	6.1574	0.8011
2015	7	2	14	26	52	0.3	1	0.14	91.4	6.1574	0.7476
2015	7	2	14	36	52	0.3	1	0.16	100.8	6.1767	0.8395
2015	7	2	14	46	52	0.3	1	0.2	66.4	6.1767	0.9824
2015	7	2	14	56	52	0.3	1	0.1	86.3	6.1767	0.5537
2015	7	2	15	6	52	0.3	1	0.18	66.7	6.1767	0.9109
2015	7	2	15	16	52	0.3	1	0.16	94.8	6.1767	0.8573
2015	7	2	15	26	52	0.3	1	0.18	82.7	6.1767	0.9824
2015	7	2	15	36	52	0.3	1	0.1	52	6.1767	0.4108

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	2	15	46	52	0.3	1	0.16	105.5	6.1961	0.8423
2015	7	2	15	56	52	0.3	1	0.09	83.9	6.1961	0.5018
2015	7	2	16	6	52	0.3	1	0.1	69.2	6.1961	0.5197
2015	7	2	16	16	52	0.3	1	0.16	87.6	6.1961	0.8602
2015	7	2	16	26	52	0.3	1	0.21	92.7	6.1961	1.129
2015	7	2	16	36	52	0.3	1	0.17	69.4	6.2154	0.8631
2015	7	2	16	46	52	0.3	1	0.16	92.3	6.2154	0.899
2015	7	2	16	56	52	0.3	1	0.13	82.7	6.2154	0.7013
2015	7	2	17	6	52	0.3	1	0.12	98.1	6.2154	0.6293
2015	7	2	17	16	52	0.3	1	0.13	88.6	6.2154	0.7372
2015	7	2	17	26	52	0.3	1	0.13	102.7	6.2154	0.7192
2015	7	2	17	36	52	0.3	1	0.13	90	6.2154	0.7372
2015	7	2	17	46	52	0.3	1	0.11	126.9	6.2154	0.5035
2015	7	2	17	56	52	0.3	1	0.11	84.6	6.2154	0.5754
2015	7	2	18	6	52	0.3	1	0.09	96.3	6.2348	0.4871
2015	7	2	18	16	52	0.3	1	0.13	110.2	6.2154	0.6833
2015	7	2	18	26	52	0.3	1	0.2	110.8	6.2348	1.0464
2015	7	2	18	36	52	0.3	1	0.14	79.2	6.2348	0.7577
2015	7	2	18	46	52	0.3	1	0.17	88.9	6.2348	0.9562
2015	7	2	18	56	52	0.3	1	0.06	152.1	6.2348	0.1624
2015	7	2	19	6	52	0.3	1	0.13	59.5	6.2348	0.6134
2015	7	2	19	16	52	0.3	1	0.13	105.1	6.2348	0.6675
2015	7	2	19	26	52	0.3	1	0.1	90	6.2348	0.5773
2015	7	2	19	36	52	0.3	1	0.18	78.3	6.2348	0.9562
2015	7	2	19	46	52	0.3	1	0.18	101.7	6.2348	0.9562
2015	7	2	19	56	52	0.3	1	0.1	116.6	6.2348	0.4691
2015	7	2	20	6	52	0.3	1	0.1	86.1	6.2542	0.5249
2015	7	2	20	16	52	0.3	1	0.18	108.8	6.2348	0.9562
2015	7	2	20	26	52	0.3	1	0.11	90	6.2542	0.6335
2015	7	2	20	36	52	0.3	1	0.14	97	6.2542	0.7422
2015	7	2	20	46	52	0.3	1	0.11	95.4	6.2542	0.5792
2015	7	2	20	56	52	0.3	1	0.17	123.7	6.2542	0.7603
2015	7	2	21	6	52	0.3	1	0.16	76	6.2542	0.8689
2015	7	2	21	16	52	0.3	1	0.12	68.2	6.2542	0.6335

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	2	21	26	52	0.3	1	0.13	91.4	6.2542	0.7422
2015	7	2	21	36	52	0.3	1	0.2	68.6	6.2542	1.0137
2015	7	2	21	46	52	0.3	1	0.16	92.3	6.2542	0.9051
2015	7	2	21	56	52	0.3	1	0.2	129	6.2542	0.8508
2015	7	2	22	6	52	0.3	1	0.17	107.7	6.2542	0.9051
2015	7	2	22	16	52	0.3	1	0.14	123.3	6.2542	0.6335
2015	7	2	22	26	52	0.3	1	0.18	97.3	6.2542	0.9956
2015	7	2	22	36	52	0.3	1	0.14	90	6.2542	0.7603
2015	7	2	22	46	52	0.3	1	0.16	92.3	6.2542	0.9051
2015	7	2	22	56	52	0.3	1	0.15	94.9	6.2735	0.8536
2015	7	2	23	6	52	0.3	1	0.18	129.9	6.2542	0.7784
2015	7	2	23	16	52	0.3	1	0.1	86.1	6.2542	0.5249
2015	7	2	23	26	52	0.3	1	0.16	90	6.2542	0.9051
2015	7	2	23	36	52	0.3	1	0.13	126.6	6.2542	0.5611
2015	7	2	23	46	52	0.3	1	0.08	120.6	6.2542	0.3982
2015	7	2	23	56	52	0.3	1	0.11	111.2	6.2542	0.5611
2015	7	3	0	6	52	0.3	1	0.18	97.5	6.2542	0.9594
2015	7	3	0	16	52	0.3	1	0.09	90	6.2542	0.5068
2015	7	3	0	26	52	0.3	1	0.12	98.1	6.2542	0.6336
2015	7	3	0	36	52	0.3	1	0.16	76	6.2542	0.8689
2015	7	3	0	46	52	0.3	1	0.12	72.6	6.2542	0.6336
2015	7	3	0	56	52	0.3	1	0.16	114.4	6.2542	0.7965
2015	7	3	1	6	52	0.3	1	0.13	117.9	6.2348	0.6134
2015	7	3	1	16	52	0.3	1	0.07	90	6.2348	0.3789
2015	7	3	1	26	52	0.3	1	0.14	99.7	6.2348	0.7397
2015	7	3	1	36	52	0.3	1	0.17	115.6	6.2348	0.8299
2015	7	3	1	46	52	0.3	1	0.22	59.9	6.2154	1.025
2015	7	3	1	56	52	0.3	1	0.14	61.6	6.2348	0.6675
2015	7	3	2	6	52	0.3	1	0.19	47.1	6.2154	0.7732
2015	7	3	2	16	52	0.3	1	0.22	61.1	6.2154	1.0429
2015	7	3	2	26	52	0.3	1	0.29	51.4	6.2154	1.2407
2015	7	3	2	36	52	0.3	1	0.19	55.5	6.2154	0.8631
2015	7	3	2	46	52	0.3	1	0.26	48.1	6.2154	1.0429
2015	7	3	2	56	52	0.3	1	0.25	49.2	6.2154	1.0429

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	3	3	6	52	0.3	1	0.23	53.1	6.1961	1.0036
2015	7	3	3	16	52	0.3	1	0.15	62.3	6.1961	0.7169
2015	7	3	3	26	52	0.3	1	0.25	55.1	6.1961	1.1291
2015	7	3	3	36	52	0.3	1	0.24	50.6	6.1961	1.0036
2015	7	3	3	46	52	0.3	1	0.21	46.9	6.1961	0.8423
2015	7	3	3	56	52	0.3	1	0.21	46.3	6.1961	0.8244
2015	7	3	4	6	52	0.3	1	0.2	50.2	6.1961	0.8602
2015	7	3	4	16	52	0.3	1	0.2	41	6.1961	0.7169
2015	7	3	4	26	52	0.3	1	0.26	36.1	6.1961	0.8244
2015	7	3	4	36	52	0.3	1	0.23	76.9	6.1961	1.2366
2015	7	3	4	46	52	0.3	1	0.2	34.8	6.1767	0.6073
2015	7	3	4	56	52	0.3	1	0.32	42.1	6.1767	1.161
2015	7	3	5	6	52	0.3	1	0.2	54.5	6.1767	0.8752
2015	7	3	5	16	52	0.3	1	0.27	52.4	6.1767	1.161
2015	7	3	5	26	52	0.3	1	0.28	34.6	6.1767	0.8752
2015	7	3	5	36	52	0.3	1	0.26	37.4	6.1574	0.8723
2015	7	3	5	46	52	0.3	1	0.38	39.1	6.1574	1.3173
2015	7	3	5	56	52	0.3	1	0.33	46.6	6.1574	1.3173
2015	7	3	6	6	52	0.3	1	0.28	20.3	6.1574	0.5341
2015	7	3	6	16	52	0.3	1	0.26	29.2	6.1574	0.6765
2015	7	3	6	26	52	0.3	1	0.31	32.5	6.138	0.9048
2015	7	3	6	36	52	0.3	1	0.29	29.4	6.138	0.7806
2015	7	3	6	46	52	0.3	1	0.23	27.3	6.138	0.5677
2015	7	3	6	56	52	0.3	1	0.34	30.6	6.138	0.9226
2015	7	3	7	6	52	0.3	1	0.33	36.1	6.138	1.0468
2015	7	3	7	16	52	0.3	1	0.27	39.5	6.1187	0.9194
2015	7	3	7	26	52	0.3	1	0.3	30.4	6.1187	0.831
2015	7	3	7	36	52	0.3	1	0.29	28.3	6.1187	0.7426
2015	7	3	7	46	52	0.3	1	0.28	22.7	6.0993	0.5815
2015	7	3	7	56	52	0.3	1	0.28	31.1	6.0993	0.7753
2015	7	3	8	6	52	0.3	1	0.25	28.2	6.0993	0.6344
2015	7	3	8	16	52	0.3	1	0.22	50.9	6.08	0.9307
2015	7	3	8	26	52	0.3	1	0.25	37.5	6.0606	0.8051
2015	7	3	8	36	52	0.3	1	0.21	24.6	6.0606	0.4725

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	3	8	46	52	0.3	1	0.22	59.9	6.0412	0.9941
2015	7	3	8	56	52	0.3	1	0.18	59.7	6.0219	0.8343
2015	7	3	9	6	52	0.3	1	0.25	56.7	6.0219	1.1124
2015	7	3	9	16	52	0.3	1	0.16	32.7	6.0219	0.4693
2015	7	3	9	26	52	0.3	1	0.22	30.1	6.0219	0.5736
2015	7	3	9	36	52	0.3	1	0.15	29.4	6.0025	0.3811
2015	7	3	9	46	52	0.3	1	0.15	52.4	6.0025	0.6062
2015	7	3	9	56	52	0.3	1	0.12	36.3	6.0025	0.3811
2015	7	3	10	6	52	0.3	1	0.15	36.1	6.0025	0.4677
2015	7	3	10	16	52	0.3	1	0.14	79.2	6.0025	0.7275
2015	7	3	10	26	52	0.3	1	0.17	60	6.0025	0.7794
2015	7	3	10	36	52	0.3	1	0.13	55.9	6.0025	0.5889
2015	7	3	10	46	52	0.3	1	0.13	90	6.0025	0.6928
2015	7	3	10	56	52	0.3	1	0.14	84.7	6.0025	0.7448
2015	7	3	11	6	52	0.3	1	0.16	58.8	6.0025	0.7448
2015	7	3	11	16	52	0.3	1	0.16	74.2	5.9832	0.794
2015	7	3	11	26	52	0.3	1	0.16	94.8	5.9832	0.8285
2015	7	3	11	36	52	0.3	1	0.11	23.4	5.9832	0.2244
2015	7	3	11	46	52	0.3	1	0.1	90	5.9832	0.5351
2015	7	3	11	56	52	0.3	1	0.13	52	5.9832	0.5523
2015	7	3	12	6	52	0.3	1	0.16	76	5.9832	0.8285
2015	7	3	12	16	52	0.3	1	0.04	57.5	5.9638	0.1892
2015	7	3	12	26	52	0.3	1	0.11	53.8	5.9638	0.4472
2015	7	3	12	36	52	0.3	1	0.15	60.1	5.9832	0.6904
2015	7	3	12	46	52	0.3	1	0.14	45	5.9832	0.5178
2015	7	3	12	56	52	0.3	1	0.18	64.4	5.9832	0.863
2015	7	3	13	6	52	0.3	1	0.09	55.7	5.9638	0.3784
2015	7	3	13	16	52	0.3	1	0.11	36.5	5.9832	0.3452
2015	7	3	13	26	52	0.3	1	0.15	57.7	5.9832	0.6559
2015	7	3	13	36	52	0.3	1	0.18	57.4	6.0025	0.814
2015	7	3	13	46	52	0.3	1	0.16	87.7	6.0025	0.866
2015	7	3	13	56	52	0.3	1	0.12	51.6	6.0025	0.5023
2015	7	3	14	6	52	0.3	1	0.08	49.9	6.0025	0.3291
2015	7	3	14	16	52	0.3	1	0.08	73.1	6.0025	0.3984

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	3	14	26	52	0.3	1	0.15	48.6	6.0025	0.5889
2015	7	3	14	36	52	0.3	1	0.1	69.9	6.0025	0.5196
2015	7	3	14	46	52	0.3	1	0.1	50.4	6.0219	0.3997
2015	7	3	14	56	52	0.3	1	0.15	70.3	6.0219	0.7299
2015	7	3	15	6	52	0.3	1	0.12	93	6.0219	0.6604
2015	7	3	15	16	52	0.3	1	0.09	87.9	6.0219	0.4692
2015	7	3	15	26	52	0.3	1	0.14	83.2	6.0219	0.7299
2015	7	3	15	36	52	0.3	1	0.14	90	6.0219	0.7299
2015	7	3	15	46	52	0.3	1	0.14	57.4	6.0412	0.6278
2015	7	3	15	56	52	0.3	1	0.15	36.9	6.0412	0.4709
2015	7	3	16	6	52	0.3	1	0.15	48.6	6.0412	0.5929
2015	7	3	16	16	52	0.3	1	0.15	53.1	6.0606	0.63
2015	7	3	16	26	52	0.3	1	0.09	94.4	6.0606	0.455
2015	7	3	16	36	52	0.3	1	0.08	76.5	6.0606	0.4375
2015	7	3	16	46	52	0.3	1	0.07	76	6.08	0.3512
2015	7	3	16	56	52	0.3	1	0.16	95.9	6.0993	0.8457
2015	7	3	17	6	52	0.3	1	0.1	84.1	6.0993	0.511
2015	7	3	17	16	52	0.3	1	0.18	78.7	6.1187	0.9724
2015	7	3	17	26	52	0.3	1	0.17	86.8	6.138	0.9402
2015	7	3	17	36	52	0.3	1	0.21	73.6	6.1574	1.0858
2015	7	3	17	46	52	0.3	1	0.09	90	6.1574	0.4806
2015	7	3	17	56	52	0.3	1	0.15	106.8	6.1767	0.768
2015	7	3	18	6	52	0.3	1	0.1	101	6.1767	0.5537
2015	7	3	18	16	52	0.3	1	0.29	87.4	6.1767	1.5717
2015	7	3	18	26	52	0.3	1	0.14	101.8	6.1961	0.7706
2015	7	3	18	36	52	0.3	1	0.12	38.4	6.1961	0.4122
2015	7	3	18	46	52	0.3	1	0.19	92	6.1961	1.0215
2015	7	3	18	56	52	0.3	1	0.24	97.9	6.1961	1.2903
2015	7	3	19	6	52	0.3	1	0.13	94.4	6.1961	0.6989
2015	7	3	19	16	52	0.3	1	0.08	69.4	6.2154	0.4315
2015	7	3	19	26	52	0.3	1	0.15	68	6.2154	0.7552
2015	7	3	19	36	52	0.3	1	0.04	118.6	6.2154	0.1978
2015	7	3	19	46	52	0.3	1	0.17	100.2	6.2154	0.899
2015	7	3	19	56	52	0.3	1	0.12	102.5	6.2154	0.6473

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	3	20	6	52	0.3	1	0.12	85.4	6.2154	0.6653
2015	7	3	20	16	52	0.3	1	0.14	120.7	6.2348	0.6675
2015	7	3	20	26	52	0.3	1	0.14	90	6.2348	0.7758
2015	7	3	20	36	52	0.3	1	0.15	84.9	6.2348	0.8118
2015	7	3	20	46	52	0.3	1	0.16	90	6.2348	0.902
2015	7	3	20	56	52	0.3	1	0.14	103.7	6.2348	0.7397
2015	7	3	21	6	52	0.3	1	0.11	107.4	6.2348	0.5773
2015	7	3	21	16	52	0.3	1	0.14	123	6.2348	0.6675
2015	7	3	21	26	52	0.3	1	0.11	133.8	6.2348	0.433
2015	7	3	21	36	52	0.3	1	0.12	118	6.2348	0.5773
2015	7	3	21	46	52	0.3	1	0.11	63.4	6.2348	0.5412
2015	7	3	21	56	52	0.3	1	0.17	115.6	6.2348	0.8299
2015	7	3	22	6	52	0.3	1	0.18	86.8	6.2348	0.9742
2015	7	3	22	16	52	0.3	1	0.19	94.9	6.2348	1.0464
2015	7	3	22	26	52	0.3	1	0.17	90	6.2348	0.9381
2015	7	3	22	36	52	0.3	1	0.12	118.6	6.2348	0.5954
2015	7	3	22	46	52	0.3	1	0.13	88.5	6.2348	0.7036
2015	7	3	22	56	52	0.3	1	0.11	98.4	6.2348	0.6134
2015	7	3	23	6	52	0.3	1	0.16	105.5	6.2348	0.8479
2015	7	3	23	16	52	0.3	1	0.08	87.5	6.2348	0.4149
2015	7	3	23	26	52	0.3	1	0.17	118	6.2348	0.8479
2015	7	3	23	36	52	0.3	1	0.2	105.8	6.2348	1.0825
2015	7	3	23	46	52	0.3	1	0.13	124.9	6.2348	0.5954
2015	7	3	23	56	52	0.3	1	0.13	117.9	6.2348	0.6134
2015	7	4	0	6	52	0.3	1	0.11	121.8	6.2348	0.5232
2015	7	4	0	16	52	0.3	1	0.06	83.3	6.2542	0.3077
2015	7	4	0	26	52	0.3	1	0.1	126.9	6.2348	0.433
2015	7	4	0	36	52	0.3	1	0.14	73.3	6.2348	0.7217
2015	7	4	0	46	52	0.3	1	0.15	90	6.2348	0.8299
2015	7	4	0	56	52	0.3	1	0.16	78.5	6.2348	0.884
2015	7	4	1	6	52	0.3	1	0.14	68.7	6.2348	0.7397
2015	7	4	1	16	52	0.3	1	0.13	94.4	6.2348	0.7036
2015	7	4	1	26	52	0.3	1	0.16	90	6.2348	0.866
2015	7	4	1	36	52	0.3	1	0.15	90	6.2348	0.848

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	4	1	46	52	0.3	1	0.13	90	6.2348	0.7397
2015	7	4	1	56	52	0.3	1	0.19	90	6.2348	1.0645
2015	7	4	2	6	52	0.3	1	0.08	80.5	6.2348	0.433
2015	7	4	2	16	52	0.3	1	0.1	113.2	6.2348	0.5052
2015	7	4	2	26	52	0.3	1	0.12	107.9	6.2348	0.6134
2015	7	4	2	36	52	0.3	1	0.17	118.1	6.2348	0.8119
2015	7	4	2	46	52	0.3	1	0.14	95.6	6.2348	0.7397
2015	7	4	2	56	52	0.3	1	0.12	99.7	6.2348	0.6315
2015	7	4	3	6	52	0.3	1	0.11	91.6	6.2348	0.6315
2015	7	4	3	16	52	0.3	1	0.09	98.1	6.2154	0.5035
2015	7	4	3	26	52	0.3	1	0.1	101.7	6.2154	0.5215
2015	7	4	3	36	52	0.3	1	0.2	90	6.2154	1.0969
2015	7	4	3	46	52	0.3	1	0.05	108.4	6.2154	0.2697
2015	7	4	3	56	52	0.3	1	0.15	48.6	6.2154	0.6114
2015	7	4	4	6	52	0.3	1	0.14	63.4	6.2154	0.6833
2015	7	4	4	16	52	0.3	1	0.25	79.3	6.2154	1.3307
2015	7	4	4	26	52	0.3	1	0.15	80.1	6.2154	0.8272
2015	7	4	4	36	52	0.3	1	0.19	92	6.2154	1.043
2015	7	4	4	46	52	0.3	1	0.19	105	6.2154	1.007
2015	7	4	4	56	52	0.3	1	0.17	112.2	6.1961	0.8782
2015	7	4	5	6	52	0.3	1	0.1	107.8	6.1961	0.5018
2015	7	4	5	16	52	0.3	1	0.12	64.1	6.1961	0.5914
2015	7	4	5	26	52	0.3	1	0.13	100.2	6.1961	0.699
2015	7	4	5	36	52	0.3	1	0.15	69.6	6.1961	0.7706
2015	7	4	5	46	52	0.3	1	0.1	102.7	6.1961	0.5556
2015	7	4	5	56	52	0.3	1	0.12	109.4	6.1961	0.6093
2015	7	4	6	6	52	0.3	1	0.16	94.8	6.1961	0.8603
2015	7	4	6	16	52	0.3	1	0.12	93.2	6.1961	0.6452
2015	7	4	6	26	52	0.3	1	0.12	110.9	6.1961	0.6094
2015	7	4	6	36	52	0.3	1	0.1	121.6	6.1767	0.4644
2015	7	4	6	46	52	0.3	1	0.13	90	6.1961	0.699
2015	7	4	6	56	52	0.3	1	0.16	109.9	6.1767	0.8395
2015	7	4	7	6	52	0.3	1	0.13	105.1	6.1767	0.6609
2015	7	4	7	16	52	0.3	1	0.17	116.6	6.1767	0.8217

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	4	7	26	52	0.3	1	0.15	98.8	6.1767	0.8038
2015	7	4	7	36	52	0.3	1	0.16	84.2	6.1767	0.8752
2015	7	4	7	46	52	0.3	1	0.13	90	6.1767	0.7323
2015	7	4	7	56	52	0.3	1	0.15	122.7	6.1767	0.6966
2015	7	4	8	6	52	0.3	1	0.13	108	6.1767	0.6609
2015	7	4	8	16	52	0.3	1	0.16	110.3	6.1574	0.8189
2015	7	4	8	26	52	0.3	1	0.13	119.2	6.1574	0.6053
2015	7	4	8	36	52	0.3	1	0.23	117.6	6.1574	1.1215
2015	7	4	8	46	52	0.3	1	0.13	124.5	6.1574	0.5697
2015	7	4	8	56	52	0.3	1	0.02	158.2	6.1574	0.0356
2015	7	4	9	6	52	0.3	1	0.07	120.1	6.1574	0.3382
2015	7	4	9	16	52	0.3	1	0.12	113	6.138	0.5855
2015	7	4	9	26	52	0.3	1	0.1	90	6.138	0.55
2015	7	4	9	36	52	0.3	1	0.15	87.5	6.138	0.7984
2015	7	4	9	46	52	0.3	1	0.06	110.6	6.138	0.2839
2015	7	4	9	56	52	0.3	1	0.1	90	6.138	0.55
2015	7	4	10	6	52	0.3	1	0.14	77.6	6.138	0.7274
2015	7	4	10	16	52	0.3	1	0.05	100.6	6.138	0.2839
2015	7	4	10	26	52	0.3	1	0.05	90	6.1187	0.2829
2015	7	4	10	36	52	0.3	1	0.08	97.4	6.1187	0.4067
2015	7	4	10	46	52	0.3	1	0.1	80.2	6.1187	0.5128
2015	7	4	10	56	52	0.3	1	0.16	92.4	6.1187	0.8487
2015	7	4	11	6	52	0.3	1	0.13	68.7	6.1187	0.6365
2015	7	4	11	16	52	0.3	1	0.03	90	6.0993	0.1586
2015	7	4	11	26	52	0.3	1	0.16	77.1	6.08	0.8429
2015	7	4	11	36	52	0.3	1	0.11	71	6.0606	0.56
2015	7	4	11	46	52	0.3	1	0.05	59.7	6.08	0.2107
2015	7	4	11	56	52	0.3	1	0.13	53.4	6.0606	0.5425
2015	7	4	12	6	52	0.3	1	0.11	83.1	6.0606	0.5775
2015	7	4	12	16	52	0.3	1	0.17	79.8	6.0606	0.875
2015	7	4	12	26	52	0.3	1	0.09	76	6.0412	0.4883
2015	7	4	12	36	52	0.3	1	0.1	90	6.0412	0.5407
2015	7	4	12	46	52	0.3	1	0.12	72.1	6.0412	0.593
2015	7	4	12	56	52	0.3	1	0.11	55.8	6.0412	0.4883

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	4	13	6	52	0.3	1	0.18	56.9	6.0219	0.7995
2015	7	4	13	16	52	0.3	1	0.13	79.6	6.0219	0.6605
2015	7	4	13	26	52	0.3	1	0.09	65.2	6.0412	0.4535
2015	7	4	13	36	52	0.3	1	0.16	82.7	6.0219	0.8169
2015	7	4	13	46	52	0.3	1	0.08	73.1	6.0412	0.4011
2015	7	4	13	56	52	0.3	1	0.11	45	6.0412	0.4011
2015	7	4	14	6	52	0.3	1	0.14	65.2	6.0219	0.6778
2015	7	4	14	16	52	0.3	1	0.18	74.2	6.0219	0.9211
2015	7	4	14	26	52	0.3	1	0.17	68	6.0219	0.8169
2015	7	4	14	36	52	0.3	1	0.14	78.2	6.0412	0.7499
2015	7	4	14	46	52	0.3	1	0.1	66.8	6.0219	0.4866
2015	7	4	14	56	52	0.3	1	0.1	82.1	6.0219	0.504
2015	7	4	15	6	52	0.3	1	0.11	81.6	6.0219	0.5909
2015	7	4	15	16	52	0.3	1	0.07	66.8	6.0412	0.3662
2015	7	4	15	26	52	0.3	1	0.11	43.8	6.0219	0.3997
2015	7	4	15	36	52	0.3	1	0.15	83.7	6.0412	0.7848
2015	7	4	15	46	52	0.3	1	0.14	91.3	6.0412	0.7674
2015	7	4	15	56	52	0.3	1	0.15	66.8	6.0412	0.7325
2015	7	4	16	6	52	0.3	1	0.13	90	6.0412	0.6802
2015	7	4	16	16	52	0.3	1	0.13	16.1	6.0412	0.1918
2015	7	4	16	26	52	0.3	1	0.07	32.3	6.0412	0.2093
2015	7	4	16	36	52	0.3	1	0.2	85.4	6.0219	1.0776
2015	7	4	16	46	52	0.3	1	0.17	109.8	6.0219	0.869
2015	7	4	16	56	52	0.3	1	0.11	61.1	6.0412	0.5058
2015	7	4	17	6	52	0.3	1	0.09	79.5	6.0606	0.4725
2015	7	4	17	16	52	0.3	1	0.25	63.1	6.0606	1.2075
2015	7	4	17	26	52	0.3	1	0.18	71.2	6.0606	0.9275
2015	7	4	17	36	52	0.3	1	0.14	80.3	6.08	0.72
2015	7	4	17	46	52	0.3	1	0.12	49.6	6.0993	0.4758
2015	7	4	17	56	52	0.3	1	0.12	64.9	6.1187	0.5658
2015	7	4	18	6	52	0.3	1	0.13	62.1	6.0606	0.595
2015	7	4	18	16	52	0.3	1	0.18	40.5	6.1187	0.6188
2015	7	4	18	26	52	0.3	1	0.14	68.7	6.138	0.7274
2015	7	4	18	36	52	0.3	1	0.16	58.8	6.138	0.7628

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	4	18	46	52	0.3	1	0.17	83.5	6.138	0.9403
2015	7	4	18	56	52	0.3	1	0.14	58.1	6.1574	0.6586
2015	7	4	19	6	52	0.3	1	0.15	66.3	6.1574	0.7298
2015	7	4	19	16	52	0.3	1	0.09	36.5	6.1574	0.3026
2015	7	4	19	26	52	0.3	1	0.12	49.6	6.138	0.479
2015	7	4	19	36	52	0.3	1	0.13	90	6.1574	0.7298
2015	7	4	19	46	52	0.3	1	0.12	102.9	6.1574	0.623
2015	7	4	19	56	52	0.3	1	0.12	97.7	6.1767	0.6609
2015	7	4	20	6	52	0.3	1	0.1	95.7	6.1767	0.5358
2015	7	4	20	16	52	0.3	1	0.17	86.6	6.1767	0.9109
2015	7	4	20	26	52	0.3	1	0.06	106.4	6.1767	0.3036
2015	7	4	20	36	52	0.3	1	0.14	101	6.1961	0.7348
2015	7	4	20	46	52	0.3	1	0.13	85.6	6.1961	0.6989
2015	7	4	20	56	52	0.3	1	0.13	115.3	6.1961	0.6452
2015	7	4	21	6	52	0.3	1	0.1	135	6.1961	0.3943
2015	7	4	21	16	52	0.3	1	0.11	90	6.1961	0.6093
2015	7	4	21	26	52	0.3	1	0.1	97.4	6.1961	0.5556
2015	7	4	21	36	52	0.3	1	0.17	103.5	6.1961	0.8961
2015	7	4	21	46	52	0.3	1	0.09	110.3	6.1961	0.4839
2015	7	4	21	56	52	0.3	1	0.17	85.6	6.1961	0.9319
2015	7	4	22	6	52	0.3	1	0.04	126	6.1961	0.1971
2015	7	4	22	16	52	0.3	1	0.14	76.6	6.1961	0.7527
2015	7	4	22	26	52	0.3	1	0.11	76.8	6.1961	0.6093
2015	7	4	22	36	52	0.3	1	0.21	95.3	6.1961	1.1649
2015	7	4	22	46	52	0.3	1	0.11	61.1	6.1961	0.5197
2015	7	4	22	56	52	0.3	1	0.12	66.2	6.1961	0.6093
2015	7	4	23	6	52	0.3	1	0.06	73.6	6.1961	0.3047
2015	7	4	23	16	52	0.3	1	0.14	100.8	6.1961	0.7527
2015	7	4	23	26	52	0.3	1	0.06	75.3	6.1961	0.3405
2015	7	4	23	36	52	0.3	1	0.13	72.5	6.1961	0.681
2015	7	4	23	46	52	0.3	1	0.08	83.2	6.1961	0.448
2015	7	4	23	56	52	0.3	1	0.2	102.4	6.1961	1.0574
2015	7	5	0	6	52	0.3	1	0.07	74.7	6.1961	0.3943
2015	7	5	0	16	52	0.3	1	0.16	78	6.1961	0.8423

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	5	0	26	52	0.3	1	0.19	107.5	6.2154	0.971
2015	7	5	0	36	52	0.3	1	0.12	93.2	6.2154	0.6474
2015	7	5	0	46	52	0.3	1	0.17	96.5	6.2154	0.953
2015	7	5	0	56	52	0.3	1	0.09	129.3	6.2154	0.3956
2015	7	5	1	6	52	0.3	1	0.19	99	6.2154	1.025
2015	7	5	1	16	52	0.3	1	0.17	86.6	6.2154	0.9171
2015	7	5	1	26	52	0.3	1	0.16	76.6	6.2154	0.8272
2015	7	5	1	36	52	0.3	1	0.1	101.3	6.2154	0.5395
2015	7	5	1	46	52	0.3	1	0.16	116.6	6.2348	0.7939
2015	7	5	1	56	52	0.3	1	0.09	115.6	6.2348	0.4511
2015	7	5	2	6	52	0.3	1	0.15	101.3	6.2348	0.8119
2015	7	5	2	16	52	0.3	1	0.15	61.7	6.2348	0.7037
2015	7	5	2	26	52	0.3	1	0.15	98.7	6.2348	0.83
2015	7	5	2	36	52	0.3	1	0.12	90	6.2542	0.6879
2015	7	5	2	46	52	0.3	1	0.15	104.3	6.2542	0.7784
2015	7	5	2	56	52	0.3	1	0.15	102.5	6.2542	0.8146
2015	7	5	3	6	52	0.3	1	0.09	119.5	6.2735	0.4178
2015	7	5	3	16	52	0.3	1	0.11	91.8	6.2929	0.5831
2015	7	5	3	26	52	0.3	1	0.11	90	6.2929	0.6378
2015	7	5	3	36	52	0.3	1	0.09	73.5	6.3122	0.4937
2015	7	5	3	46	52	0.3	1	0.16	84.3	6.3122	0.9142
2015	7	5	3	56	52	0.3	1	0.15	97.6	6.3316	0.8255
2015	7	5	4	6	52	0.3	1	0.16	124.7	6.3316	0.7154
2015	7	5	4	16	52	0.3	1	0.2	115.7	6.3316	1.0273
2015	7	5	4	26	52	0.3	1	0.13	84	6.3509	0.6994
2015	7	5	4	36	52	0.3	1	0.13	112.1	6.3509	0.681
2015	7	5	4	46	52	0.3	1	0.21	95.4	6.3509	1.1779
2015	7	5	4	56	52	0.3	1	0.19	108.7	6.3509	1.0306
2015	7	5	5	6	52	0.3	1	0.12	102.2	6.3509	0.681
2015	7	5	5	16	52	0.3	1	0.09	67.1	6.3703	0.4801
2015	7	5	5	26	52	0.3	1	0.17	85.5	6.3703	0.9417
2015	7	5	5	36	52	0.3	1	0.12	93.2	6.3703	0.6647
2015	7	5	5	46	52	0.3	1	0.11	79.7	6.3703	0.6093
2015	7	5	5	56	52	0.3	1	0.16	92.4	6.3703	0.8863

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	5	6	6	52	0.3	1	0.13	112.1	6.3703	0.6832
2015	7	5	6	16	52	0.3	1	0.05	100.6	6.3703	0.2954
2015	7	5	6	26	52	0.3	1	0.12	98.1	6.3703	0.6463
2015	7	5	6	36	52	0.3	1	0.16	118.1	6.3703	0.794
2015	7	5	6	46	52	0.3	1	0.2	116.6	6.3703	0.9971
2015	7	5	6	56	52	0.3	1	0.2	92.8	6.3897	1.1486
2015	7	5	7	6	52	0.3	1	0.12	93.2	6.3897	0.6669
2015	7	5	7	16	52	0.3	1	0.14	123.7	6.3897	0.6669
2015	7	5	7	26	52	0.3	1	0.19	91	6.3897	1.093
2015	7	5	7	36	52	0.3	1	0.14	103.4	6.3897	0.778
2015	7	5	7	46	52	0.3	1	0.2	109.9	6.3897	1.0744
2015	7	5	7	56	52	0.3	1	0.16	108.4	6.3897	0.8336
2015	7	5	8	6	52	0.3	1	0.16	63.4	6.3897	0.8151
2015	7	5	8	16	52	0.3	1	0.25	83.3	6.3897	1.4264
2015	7	5	8	26	52	0.3	1	0.15	92.5	6.3897	0.8521
2015	7	5	8	36	52	0.3	1	0.09	72.3	6.3897	0.4631
2015	7	5	8	46	52	0.3	1	0.11	102.3	6.409	0.5947
2015	7	5	8	56	52	0.3	1	0.11	173.3	6.3897	0.0741
2015	7	5	9	6	52	0.3	1	0.13	156.6	6.3897	0.2964
2015	7	5	9	16	52	0.3	1	0.11	155.7	6.409	0.2602
2015	7	5	9	26	52	0.3	1	0.11	64.2	6.3897	0.5372
2015	7	5	9	36	52	0.3	1	0.14	67.7	6.409	0.7248
2015	7	5	9	46	52	0.3	1	0.17	94.5	6.409	0.9478
2015	7	5	9	56	52	0.3	1	0.14	75	6.409	0.762
2015	7	5	10	6	52	0.3	1	0.11	59	6.3897	0.5557
2015	7	5	10	16	52	0.3	1	0.13	78.4	6.409	0.7248
2015	7	5	10	26	52	0.3	1	0.15	85	6.409	0.8549
2015	7	5	10	36	52	0.3	1	0.17	74.4	6.3897	0.9262
2015	7	5	10	46	52	0.3	1	0.28	64.9	6.3897	1.4264
2015	7	5	10	56	52	0.3	1	0.12	77.8	6.3897	0.6854
2015	7	5	11	6	52	0.3	1	0.14	97.9	6.3897	0.7965
2015	7	5	11	16	52	0.3	1	0.22	90	6.3897	1.2411
2015	7	5	11	26	52	0.3	1	0.2	88.2	6.3897	1.1485
2015	7	5	11	36	52	0.3	1	0.13	68.7	6.3897	0.6669

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	5	11	46	52	0.3	1	0.21	116.2	6.3897	1.0559
2015	7	5	11	56	52	0.3	1	0.12	67.6	6.3703	0.6278
2015	7	5	12	6	52	0.3	1	0.18	88.9	6.3703	0.9971
2015	7	5	12	16	52	0.3	1	0.25	58	6.3703	1.1817
2015	7	5	12	26	52	0.3	1	0.12	81.9	6.3703	0.6462
2015	7	5	12	36	52	0.3	1	0.2	70.7	6.3703	1.0524
2015	7	5	12	46	52	0.3	1	0.13	74.2	6.3703	0.7201
2015	7	5	12	56	52	0.3	1	0.19	70.9	6.3703	1.0155
2015	7	5	13	6	52	0.3	1	0.17	23.1	6.3703	0.3693
2015	7	5	13	16	52	0.3	1	0.15	71.2	6.3703	0.8124
2015	7	5	13	26	52	0.3	1	0.15	62.9	6.3703	0.757
2015	7	5	13	36	52	0.3	1	0.12	63.4	6.3703	0.6278
2015	7	5	13	46	52	0.3	1	0.11	24.3	6.3703	0.2585
2015	7	5	13	56	52	0.3	1	0.1	20.8	6.3703	0.2031
2015	7	5	14	6	52	0.3	1	0.07	32.9	6.3703	0.2031
2015	7	5	14	16	52	0.3	1	0.05	76	6.3509	0.2944
2015	7	5	14	26	52	0.3	1	0.1	66.8	6.3509	0.5153
2015	7	5	14	36	52	0.3	1	0.14	70.7	6.3703	0.7385
2015	7	5	14	46	52	0.3	1	0.13	103.3	6.3703	0.7016
2015	7	5	14	56	52	0.3	1	0.16	349.4	6.3703	-0.1662
2015	7	5	15	6	52	0.3	1	0.19	0	6.3703	0
2015	7	5	15	16	52	0.3	1	0.28	351.1	6.3703	-0.24
2015	7	5	15	26	52	0.3	1	0.3	1.3	6.3703	0.0369
2015	7	5	15	36	52	0.3	1	0.12	7.9	6.3509	0.092
2015	7	5	15	46	52	0.3	1	0.13	18	6.3509	0.2208
2015	7	5	15	56	52	0.3	1	0.11	42.6	6.3509	0.4233
2015	7	5	16	6	52	0.3	1	0.14	358.7	6.3509	-0.0184
2015	7	5	16	16	52	0.3	1	0.22	11.1	6.3703	0.24
2015	7	5	16	26	52	0.3	1	0.2	60.9	6.3703	0.9601
2015	7	5	16	36	52	0.3	1	0.16	75.7	6.3703	0.8678
2015	7	5	16	46	52	0.3	1	0.18	58.3	6.3703	0.8678
2015	7	5	16	56	52	0.3	1	0.17	54.2	6.3703	0.7939
2015	7	5	17	6	52	0.3	1	0.17	63.9	6.3703	0.8678
2015	7	5	17	16	52	0.3	1	0.09	52.7	6.3703	0.3877

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	5	17	26	52	0.3	1	0.16	69.7	6.3703	0.8493
2015	7	5	17	36	52	0.3	1	0.24	91.6	6.3703	1.3293
2015	7	5	17	46	52	0.3	1	0.25	85.4	6.3703	1.3847
2015	7	5	17	56	52	0.3	1	0.11	96.7	6.3703	0.6277
2015	7	5	18	6	52	0.3	1	0.14	115.3	6.3703	0.7016
2015	7	5	18	16	52	0.3	1	0.1	72.2	6.3509	0.5153
2015	7	5	18	26	52	0.3	1	0.05	315	6.3509	-0.184
2015	7	5	18	36	52	0.3	1	0.07	98.5	6.3509	0.3681
2015	7	5	18	46	52	0.3	1	0.18	120.8	6.3509	0.8649
2015	7	5	18	56	52	0.3	1	0.21	112.5	6.3509	1.0674
2015	7	5	19	6	52	0.3	1	0.18	94.2	6.3509	1.0122
2015	7	5	19	16	52	0.3	1	0.17	98	6.3509	0.9201
2015	7	5	19	26	52	0.3	1	0.18	105.1	6.3509	0.957
2015	7	5	19	36	52	0.3	1	0.26	109.6	6.3509	1.3986
2015	7	5	19	46	52	0.3	1	0.14	103.4	6.3509	0.7729
2015	7	5	19	56	52	0.3	1	0.07	77.2	6.3509	0.4049
2015	7	5	20	6	52	0.3	1	0.15	92.5	6.3509	0.8281
2015	7	5	20	16	52	0.3	1	0.17	115.6	6.3509	0.8833
2015	7	5	20	26	52	0.3	1	0.12	107.9	6.3509	0.6257
2015	7	5	20	36	52	0.3	1	0.19	65.2	6.3509	0.957
2015	7	5	20	46	52	0.3	1	0.21	97.2	6.3509	1.1594
2015	7	5	20	56	52	0.3	1	0.14	69	6.3509	0.7177
2015	7	5	21	6	52	0.3	1	0.11	56.3	6.3509	0.4969
2015	7	5	21	16	52	0.3	1	0.16	91.2	6.3509	0.9018
2015	7	5	21	26	52	0.3	1	0.16	93.5	6.3703	0.9047
2015	7	5	21	36	52	0.3	1	0.07	71.6	6.3509	0.3865
2015	7	5	21	46	52	0.3	1	0.12	115.2	6.3509	0.6257
2015	7	5	21	56	52	0.3	1	0.1	114	6.3509	0.4969
2015	7	5	22	6	52	0.3	1	0.13	52	6.3509	0.5889
2015	7	5	22	16	52	0.3	1	0.2	95.5	6.3509	1.141
2015	7	5	22	26	52	0.3	1	0.14	88.6	6.3703	0.7755
2015	7	5	22	36	52	0.3	1	0.12	85.1	6.3703	0.6462
2015	7	5	22	46	52	0.3	1	0.21	103.8	6.3703	1.1263
2015	7	5	22	56	52	0.3	1	0.1	105.9	6.3509	0.5153

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	5	23	6	52	0.3	1	0.08	78.7	6.3509	0.4601
2015	7	5	23	16	52	0.3	1	0.17	84.5	6.3509	0.957
2015	7	5	23	26	52	0.3	1	0.15	58.4	6.3509	0.7177
2015	7	5	23	36	52	0.3	1	0.15	90	6.3509	0.8282
2015	7	5	23	46	52	0.3	1	0.18	93.2	6.3509	0.9938
2015	7	5	23	56	52	0.3	1	0.17	100.2	6.3703	0.9232
2015	7	6	0	6	52	0.3	1	0.12	107.9	6.3509	0.6257
2015	7	6	0	16	52	0.3	1	0.19	113.1	6.3509	0.9938
2015	7	6	0	26	52	0.3	1	0.19	98.1	6.3703	1.034
2015	7	6	0	36	52	0.3	1	0.17	81.3	6.3509	0.957
2015	7	6	0	46	52	0.3	1	0.16	112.2	6.3703	0.8124
2015	7	6	0	56	52	0.3	1	0.13	88.6	6.3703	0.7386
2015	7	6	1	6	52	0.3	1	0.14	113.6	6.3703	0.7201
2015	7	6	1	16	52	0.3	1	0.15	124	6.3703	0.6832
2015	7	6	1	26	52	0.3	1	0.14	104.7	6.3703	0.7755
2015	7	6	1	36	52	0.3	1	0.11	90	6.3703	0.6093
2015	7	6	1	46	52	0.3	1	0.16	108.4	6.3703	0.8309
2015	7	6	1	56	52	0.3	1	0.16	102.7	6.3703	0.9048
2015	7	6	2	6	52	0.3	1	0.14	81.9	6.3703	0.7755
2015	7	6	2	16	52	0.3	1	0.13	100.4	6.3703	0.7016
2015	7	6	2	26	52	0.3	1	0.1	108.4	6.3703	0.5539
2015	7	6	2	36	52	0.3	1	0.16	117.6	6.3897	0.778
2015	7	6	2	46	52	0.3	1	0.2	113.6	6.3897	1.0189
2015	7	6	2	56	52	0.3	1	0.19	94.8	6.3897	1.093
2015	7	6	3	6	52	0.3	1	0.12	105.9	6.3897	0.6484
2015	7	6	3	16	52	0.3	1	0.12	115.1	6.3897	0.5928
2015	7	6	3	26	52	0.3	1	0.13	90	6.3897	0.7595
2015	7	6	3	36	52	0.3	1	0.16	113.4	6.3897	0.8151
2015	7	6	3	46	52	0.3	1	0.14	114.1	6.3897	0.7039
2015	7	6	3	56	52	0.3	1	0.15	120.5	6.3897	0.7225
2015	7	6	4	6	52	0.3	1	0.14	104	6.3897	0.741
2015	7	6	4	16	52	0.3	1	0.19	83.1	6.3897	1.0744
2015	7	6	4	26	52	0.3	1	0.17	108.8	6.3897	0.9262
2015	7	6	4	36	52	0.3	1	0.13	105.1	6.3897	0.6854

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	6	4	46	52	0.3	1	0.12	69.6	6.3897	0.6484
2015	7	6	4	56	52	0.3	1	0.12	116.6	6.3897	0.6298
2015	7	6	5	6	52	0.3	1	0.11	90	6.3897	0.6484
2015	7	6	5	16	52	0.3	1	0.25	93	6.3897	1.4264
2015	7	6	5	26	52	0.3	1	0.2	114.4	6.3897	1.0189
2015	7	6	5	36	52	0.3	1	0.14	88.6	6.3897	0.7781
2015	7	6	5	46	52	0.3	1	0.11	129.2	6.3897	0.5002
2015	7	6	5	56	52	0.3	1	0.17	103.2	6.3897	0.9448
2015	7	6	6	6	52	0.3	1	0.17	104.6	6.3897	0.9263
2015	7	6	6	16	52	0.3	1	0.09	90	6.3897	0.5187
2015	7	6	6	26	52	0.3	1	0.04	116.6	6.3897	0.2223
2015	7	6	6	36	52	0.3	1	0.15	107.7	6.3897	0.8151
2015	7	6	6	46	52	0.3	1	0.16	91.1	6.3897	0.9263
2015	7	6	6	56	52	0.3	1	0.22	123	6.3897	1.0559
2015	7	6	7	6	52	0.3	1	0.16	78.2	6.3897	0.8892
2015	7	6	7	16	52	0.3	1	0.17	78.7	6.409	0.9293
2015	7	6	7	26	52	0.3	1	0.12	117.3	6.409	0.6133
2015	7	6	7	36	52	0.3	1	0.15	118.2	6.409	0.762
2015	7	6	7	46	52	0.3	1	0.12	102.9	6.409	0.6505
2015	7	6	7	56	52	0.3	1	0.18	84.7	6.409	1.0036
2015	7	6	8	6	52	0.3	1	0.2	85.4	6.409	1.1523
2015	7	6	8	16	52	0.3	1	0.18	73.2	6.409	0.985
2015	7	6	8	26	52	0.3	1	0.22	89.1	6.409	1.2266
2015	7	6	8	36	52	0.3	1	0.21	108.2	6.409	1.1337
2015	7	6	8	46	52	0.3	1	0.18	96.1	6.409	1.0408
2015	7	6	8	56	52	0.3	1	0.16	88.9	6.409	0.9293
2015	7	6	9	6	52	0.3	1	0.18	63.9	6.409	0.9107
2015	7	6	9	16	52	0.3	1	0.18	101.7	6.409	0.985
2015	7	6	9	26	52	0.3	1	0.1	101	6.409	0.5761
2015	7	6	9	36	52	0.3	1	0.17	107.7	6.409	0.9292
2015	7	6	9	46	52	0.3	1	0.15	81.2	6.409	0.8363
2015	7	6	9	56	52	0.3	1	0.16	85.4	6.409	0.9292
2015	7	6	10	6	52	0.3	1	0.19	61.2	6.4477	0.954
2015	7	6	10	16	52	0.3	1	0.19	85.1	6.4284	1.0814

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	6	10	26	52	0.3	1	0.18	51.5	6.4284	0.8204
2015	7	6	10	36	52	0.3	1	0.11	57.3	6.409	0.5204
2015	7	6	10	46	52	0.3	1	0.19	60.8	6.409	0.9292
2015	7	6	10	56	52	0.3	1	0.16	76.8	6.409	0.8735
2015	7	6	11	6	52	0.3	1	0.18	74.5	6.409	1.0036
2015	7	6	11	16	52	0.3	1	0.21	72.1	6.409	1.1523
2015	7	6	11	26	52	0.3	1	0.15	52.4	6.409	0.6505
2015	7	6	11	36	52	0.3	1	0.21	66.6	6.409	1.1151
2015	7	6	11	46	52	0.3	1	0.14	62.9	6.409	0.7248
2015	7	6	11	56	52	0.3	1	0.19	72.2	6.409	1.0407
2015	7	6	12	6	52	0.3	1	0.22	80.4	6.409	1.208
2015	7	6	12	16	52	0.3	1	0.13	77	6.409	0.7248
2015	7	6	12	26	52	0.3	1	0.21	54	6.409	0.9478
2015	7	6	12	36	52	0.3	1	0.19	67.5	6.409	0.985
2015	7	6	12	46	52	0.3	1	0.15	93.7	6.409	0.8735
2015	7	6	12	56	52	0.3	1	0.18	66.7	6.409	0.9478
2015	7	6	13	6	52	0.3	1	0.14	79.2	6.409	0.7805
2015	7	6	13	16	52	0.3	1	0.25	52.1	6.409	1.0965
2015	7	6	13	26	52	0.3	1	0.17	65.5	6.409	0.8549
2015	7	6	13	36	52	0.3	1	0.21	63.4	6.409	1.0779
2015	7	6	13	46	52	0.3	1	0.19	45	6.409	0.7434
2015	7	6	13	56	52	0.3	1	0.15	92.5	6.409	0.8363
2015	7	6	14	6	52	0.3	1	0.18	69.2	6.4284	0.9322
2015	7	6	14	16	52	0.3	1	0.19	59.9	6.409	0.9292
2015	7	6	14	26	52	0.3	1	0.15	72.7	6.409	0.8363
2015	7	6	14	36	52	0.3	1	0.21	71.8	6.409	1.1336
2015	7	6	14	46	52	0.3	1	0.2	51.8	6.409	0.8734
2015	7	6	14	56	52	0.3	1	0.2	68.6	6.409	1.0407
2015	7	6	15	6	52	0.3	1	0.18	71.9	6.409	0.9663
2015	7	6	15	16	52	0.3	1	0.12	87	6.409	0.7062
2015	7	6	15	26	52	0.3	1	0.12	101	6.409	0.669
2015	7	6	15	36	52	0.3	1	0.2	80.4	6.409	1.0964
2015	7	6	15	46	52	0.3	1	0.19	92	6.409	1.0593
2015	7	6	15	56	52	0.3	1	0.11	71	6.4284	0.5966

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	6	16	6	52	0.3	1	0.23	69.3	6.409	1.2265
2015	7	6	16	16	52	0.3	1	0.17	52.2	6.409	0.7433
2015	7	6	16	26	52	0.3	1	0.25	61.4	6.409	1.2637
2015	7	6	16	36	52	0.3	1	0.23	57.5	6.409	1.0778
2015	7	6	16	46	52	0.3	1	0.23	65.6	6.409	1.1893
2015	7	6	16	56	52	0.3	1	0.19	64.7	6.409	0.9849
2015	7	6	17	6	52	0.3	1	0.14	101.8	6.409	0.7991
2015	7	6	17	16	52	0.3	1	0.17	109.8	6.409	0.9292
2015	7	6	17	26	52	0.3	1	0.14	90	6.3897	0.7965
2015	7	6	17	36	52	0.3	1	0.11	79.4	6.3897	0.5927
2015	7	6	17	46	52	0.3	1	0.18	93.2	6.3897	1.0002
2015	7	6	17	56	52	0.3	1	0.06	66	6.3897	0.3334
2015	7	6	18	6	52	0.3	1	0.18	88.9	6.3897	1.0002
2015	7	6	18	16	52	0.3	1	0.15	102.3	6.3897	0.8521
2015	7	6	18	26	52	0.3	1	0.14	90	6.409	0.7991
2015	7	6	18	36	52	0.3	1	0.13	87.1	6.3897	0.7409
2015	7	6	18	46	52	0.3	1	0.1	45	6.3897	0.4075
2015	7	6	18	56	52	0.3	1	0.08	111.4	6.3897	0.426
2015	7	6	19	6	52	0.3	1	0.16	88.8	6.3897	0.9076
2015	7	6	19	16	52	0.3	1	0.23	99.7	6.3897	1.2966
2015	7	6	19	26	52	0.3	1	0.21	111	6.3897	1.1114
2015	7	6	19	36	52	0.3	1	0.13	94.4	6.3897	0.7224
2015	7	6	19	46	52	0.3	1	0.17	107.7	6.3897	0.9262
2015	7	6	19	56	52	0.3	1	0.1	101	6.3897	0.5742
2015	7	6	20	6	52	0.3	1	0.17	88.9	6.3897	0.9447
2015	7	6	20	16	52	0.3	1	0.17	73	6.409	0.9106
2015	7	6	20	26	52	0.3	1	0.16	110.3	6.3897	0.8521
2015	7	6	20	36	52	0.3	1	0.15	104.9	6.3897	0.8335
2015	7	6	20	46	52	0.3	1	0.16	104.3	6.3897	0.8706
2015	7	6	20	56	52	0.3	1	0.15	74.7	6.3897	0.815
2015	7	6	21	6	52	0.3	1	0.15	94.9	6.3897	0.8706
2015	7	6	21	16	52	0.3	1	0.09	98.1	6.3897	0.5187
2015	7	6	21	26	52	0.3	1	0.18	84.7	6.3897	1.0003
2015	7	6	21	36	52	0.3	1	0.1	69.9	6.3897	0.5557

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	6	21	46	52	0.3	1	0.21	85.5	6.3897	1.167
2015	7	6	21	56	52	0.3	1	0.15	103.7	6.3897	0.8336
2015	7	6	22	6	52	0.3	1	0.16	92.4	6.3897	0.8891
2015	7	6	22	16	52	0.3	1	0.13	106.1	6.3897	0.7039
2015	7	6	22	26	52	0.3	1	0.19	90	6.3897	1.0929
2015	7	6	22	36	52	0.3	1	0.16	84.2	6.3897	0.9077
2015	7	6	22	46	52	0.3	1	0.2	102	6.3897	1.1299
2015	7	6	22	56	52	0.3	1	0.2	107.2	6.3897	1.0744
2015	7	6	23	6	52	0.3	1	0.19	105.7	6.3897	1.0558
2015	7	6	23	16	52	0.3	1	0.19	120.1	6.409	0.9292
2015	7	6	23	26	52	0.3	1	0.11	101.6	6.409	0.6319
2015	7	6	23	36	52	0.3	1	0.22	88.3	6.3897	1.2411
2015	7	6	23	46	52	0.3	1	0.18	117.5	6.409	0.9292
2015	7	6	23	56	52	0.3	1	0.19	103.1	6.409	1.0407
2015	7	7	0	6	52	0.3	1	0.12	108.4	6.409	0.669
2015	7	7	0	16	52	0.3	1	0.13	88.5	6.409	0.7248
2015	7	7	0	26	52	0.3	1	0.14	90	6.409	0.7805
2015	7	7	0	36	52	0.3	1	0.15	88.8	6.409	0.8549
2015	7	7	0	46	52	0.3	1	0.14	118.4	6.409	0.6876
2015	7	7	0	56	52	0.3	1	0.18	88.9	6.409	1.0035
2015	7	7	1	6	52	0.3	1	0.17	86.7	6.409	0.9664
2015	7	7	1	16	52	0.3	1	0.16	126.6	6.409	0.7248
2015	7	7	1	26	52	0.3	1	0.15	101.3	6.409	0.8363
2015	7	7	1	36	52	0.3	1	0.23	123.2	6.409	1.0779
2015	7	7	1	46	52	0.3	1	0.15	90	6.409	0.8549
2015	7	7	1	56	52	0.3	1	0.08	90	6.409	0.4274
2015	7	7	2	6	52	0.3	1	0.18	122.8	6.409	0.8363
2015	7	7	2	16	52	0.3	1	0.15	100.1	6.409	0.8363
2015	7	7	2	26	52	0.3	1	0.2	103.1	6.409	1.1151
2015	7	7	2	36	52	0.3	1	0.18	111	6.409	0.9664
2015	7	7	2	46	52	0.3	1	0.2	91.8	6.409	1.1522
2015	7	7	2	56	52	0.3	1	0.21	107	6.409	1.1522
2015	7	7	3	6	52	0.3	1	0.16	126.6	6.409	0.7248
2015	7	7	3	16	52	0.3	1	0.14	81.9	6.409	0.7806

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	7	3	26	52	0.3	1	0.17	117.1	6.409	0.8363
2015	7	7	3	36	52	0.3	1	0.16	99.3	6.409	0.9106
2015	7	7	3	46	52	0.3	1	0.19	102.8	6.3897	1.0559
2015	7	7	3	56	52	0.3	1	0.22	93.4	6.3897	1.2597
2015	7	7	4	6	52	0.3	1	0.17	97.8	6.3897	0.9447
2015	7	7	4	16	52	0.3	1	0.13	96	6.3897	0.7039
2015	7	7	4	26	52	0.3	1	0.1	97.4	6.3897	0.5743
2015	7	7	4	36	52	0.3	1	0.18	77.7	6.3897	1.0189
2015	7	7	4	46	52	0.3	1	0.13	121.2	6.3897	0.6113
2015	7	7	4	56	52	0.3	1	0.12	54.1	6.3897	0.5372
2015	7	7	5	6	52	0.3	1	0.14	149.9	6.409	0.4089
2015	7	7	5	16	52	0.3	1	0.11	115.8	6.409	0.539
2015	7	7	5	26	52	0.3	1	0.14	81.9	6.409	0.7806
2015	7	7	5	36	52	0.3	1	0.15	90	6.3897	0.8521
2015	7	7	5	46	52	0.3	1	0.13	114.7	6.3897	0.6854
2015	7	7	5	56	52	0.3	1	0.23	104.2	6.3897	1.2412
2015	7	7	6	6	52	0.3	1	0.2	115.3	6.3897	1.0189
2015	7	7	6	16	52	0.3	1	0.14	123.3	6.3897	0.6484
2015	7	7	6	26	52	0.3	1	0.15	102.8	6.3897	0.8151
2015	7	7	6	36	52	0.3	1	0.14	99.2	6.3897	0.7966
2015	7	7	6	46	52	0.3	1	0.19	76	6.3897	1.0374
2015	7	7	6	56	52	0.3	1	0.16	98.3	6.3897	0.8892
2015	7	7	7	6	52	0.3	1	0.13	107.5	6.409	0.7062
2015	7	7	7	16	52	0.3	1	0.22	94.3	6.409	1.2266
2015	7	7	7	26	52	0.3	1	0.18	84.8	6.409	1.0222
2015	7	7	7	36	52	0.3	1	0.18	108.1	6.409	0.9664
2015	7	7	7	46	52	0.3	1	0.17	74.4	6.409	0.9292
2015	7	7	7	56	52	0.3	1	0.13	84.1	6.409	0.7248
2015	7	7	8	6	52	0.3	1	0.12	105.9	6.409	0.6505
2015	7	7	8	16	52	0.3	1	0.16	118.1	6.409	0.7991
2015	7	7	8	26	52	0.3	1	0.15	92.5	6.3897	0.8521
2015	7	7	8	36	52	0.3	1	0.17	85.7	6.409	0.985
2015	7	7	8	46	52	0.3	1	0.2	81.5	6.409	1.1151
2015	7	7	8	56	52	0.3	1	0.16	70.4	6.409	0.8363

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	7	9	6	52	0.3	1	0.13	70.6	6.409	0.6876
2015	7	7	9	16	52	0.3	1	0.18	95.3	6.409	1.0036
2015	7	7	9	26	52	0.3	1	0.21	83.9	6.3897	1.2041
2015	7	7	9	36	52	0.3	1	0.15	83.7	6.409	0.8363
2015	7	7	9	46	52	0.3	1	0.09	81.3	6.3897	0.4816
2015	7	7	9	56	52	0.3	1	0.14	85.9	6.409	0.7806
2015	7	7	10	6	52	0.3	1	0.13	114.7	6.3897	0.6854
2015	7	7	10	16	52	0.3	1	0.12	99.7	6.3897	0.6484
2015	7	7	10	26	52	0.3	1	0.17	102.2	6.3897	0.9447
2015	7	7	10	36	52	0.3	1	0.13	60.3	6.3897	0.6483
2015	7	7	10	46	52	0.3	1	0.16	65.6	6.3897	0.8151
2015	7	7	10	56	52	0.3	1	0.13	78.7	6.3703	0.7386
2015	7	7	11	6	52	0.3	1	0.12	73	6.3703	0.6647
2015	7	7	11	16	52	0.3	1	0.15	58.4	6.3703	0.7201
2015	7	7	11	26	52	0.3	1	0.08	70.8	6.3703	0.4247
2015	7	7	11	36	52	0.3	1	0.13	54	6.3703	0.6093
2015	7	7	11	46	52	0.3	1	0.16	74.2	6.3703	0.8493
2015	7	7	11	56	52	0.3	1	0.12	79	6.3509	0.6625
2015	7	7	12	6	52	0.3	1	0.17	66.9	6.3509	0.865
2015	7	7	12	16	52	0.3	1	0.14	67.2	6.3509	0.6993
2015	7	7	12	26	52	0.3	1	0.19	88	6.3509	1.049
2015	7	7	12	36	52	0.3	1	0.09	85.8	6.3509	0.4969
2015	7	7	12	46	52	0.3	1	0.18	83.7	6.3703	0.997
2015	7	7	12	56	52	0.3	1	0.17	56.3	6.3703	0.7755
2015	7	7	13	6	52	0.3	1	0.18	26.6	6.3703	0.4431
2015	7	7	13	16	52	0.3	1	0.15	68.4	6.3703	0.7939
2015	7	7	13	26	52	0.3	1	0.18	64.4	6.3897	0.9262
2015	7	7	13	36	52	0.3	1	0.17	63.9	6.409	0.8734
2015	7	7	13	46	52	0.3	1	0.15	67.5	6.409	0.7619
2015	7	7	13	56	52	0.3	1	0.16	65	6.409	0.8363
2015	7	7	14	6	52	0.3	1	0.22	58.9	6.409	1.0778
2015	7	7	14	16	52	0.3	1	0.18	66.7	6.4284	0.9508
2015	7	7	14	26	52	0.3	1	0.23	61.6	6.4284	1.1746
2015	7	7	14	36	52	0.3	1	0.17	51.2	6.4284	0.7644

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	7	14	46	52	0.3	1	0.18	61	6.4284	0.8763
2015	7	7	14	56	52	0.3	1	0.23	43.3	6.4284	0.8949
2015	7	7	15	6	52	0.3	1	0.22	63	6.4477	1.1035
2015	7	7	15	16	52	0.3	1	0.25	77.2	6.4477	1.4028
2015	7	7	15	26	52	0.3	1	0.26	63.4	6.4477	1.3093
2015	7	7	15	36	52	0.3	1	0.2	76.9	6.4477	1.1222
2015	7	7	15	46	52	0.3	1	0.22	72.6	6.4477	1.197
2015	7	7	15	56	52	0.3	1	0.21	73.3	6.4477	1.1222
2015	7	7	16	6	52	0.3	1	0.25	57.8	6.4671	1.2197
2015	7	7	16	16	52	0.3	1	0.23	77.6	6.4671	1.276
2015	7	7	16	26	52	0.3	1	0.17	84.5	6.4671	0.9757
2015	7	7	16	36	52	0.3	1	0.14	62.9	6.4671	0.7318
2015	7	7	16	46	52	0.3	1	0.21	62.7	6.4671	1.0883
2015	7	7	16	56	52	0.3	1	0.14	97	6.4864	0.7718
2015	7	7	17	6	52	0.3	1	0.28	60.8	6.4864	1.4118
2015	7	7	17	16	52	0.3	1	0.19	78.3	6.4864	1.0918
2015	7	7	17	26	52	0.3	1	0.19	67.5	6.4864	0.9977
2015	7	7	17	36	52	0.3	1	0.13	85.8	6.4864	0.7718
2015	7	7	17	46	52	0.3	1	0.18	92.1	6.4864	1.0353
2015	7	7	17	56	52	0.3	1	0.15	95.1	6.4864	0.8471
2015	7	7	18	6	52	0.3	1	0.22	77.2	6.5058	1.2464
2015	7	7	18	16	52	0.3	1	0.21	93.6	6.5058	1.2086
2015	7	7	18	26	52	0.3	1	0.25	102.8	6.5058	1.4163
2015	7	7	18	36	52	0.3	1	0.18	64.4	6.5058	0.9442
2015	7	7	18	46	52	0.3	1	0.16	67.8	6.4864	0.8283
2015	7	7	18	56	52	0.3	1	0.21	93.5	6.5058	1.2275
2015	7	7	19	6	52	0.3	1	0.16	75.7	6.5058	0.8876
2015	7	7	19	16	52	0.3	1	0.22	107.4	6.5252	1.2125
2015	7	7	19	26	52	0.3	1	0.19	90	6.5445	1.0833
2015	7	7	19	36	52	0.3	1	0.16	87.6	6.5639	0.9152
2015	7	7	19	46	52	0.3	1	0.17	99.8	6.5445	0.9883
2015	7	7	19	56	52	0.3	1	0.18	105.1	6.5639	0.9914
2015	7	7	20	6	52	0.3	1	0.17	90	6.5832	1.0137
2015	7	7	20	16	52	0.3	1	0.16	132.5	6.5832	0.6885

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	7	20	26	52	0.3	1	0.16	83.9	6.5832	0.8989
2015	7	7	20	36	52	0.3	1	0.11	107.4	6.6026	0.614
2015	7	7	20	46	52	0.3	1	0.21	101.7	6.6026	1.2088
2015	7	7	20	56	52	0.3	1	0.22	90.9	6.6026	1.2663
2015	7	7	21	6	52	0.3	1	0.15	121.6	6.6026	0.7483
2015	7	7	21	16	52	0.3	1	0.25	86.2	6.6026	1.4582
2015	7	7	21	26	52	0.3	1	0.21	85.6	6.6219	1.2511
2015	7	7	21	36	52	0.3	1	0.22	100.3	6.6219	1.2703
2015	7	7	21	46	52	0.3	1	0.25	99.7	6.6219	1.4628
2015	7	7	21	56	52	0.3	1	0.21	81.9	6.6219	1.2126
2015	7	7	22	6	52	0.3	1	0.23	74.6	6.6219	1.3281
2015	7	7	22	16	52	0.3	1	0.23	95	6.6219	1.3281
2015	7	7	22	26	52	0.3	1	0.21	85.5	6.6219	1.2318
2015	7	7	22	36	52	0.3	1	0.26	90	6.6219	1.5205
2015	7	7	22	46	52	0.3	1	0.24	72.6	6.6219	1.3473
2015	7	7	22	56	52	0.3	1	0.12	96.3	6.6219	0.6929
2015	7	7	23	6	52	0.3	1	0.24	83.1	6.6219	1.4243
2015	7	7	23	16	52	0.3	1	0.12	64.8	6.6219	0.6544
2015	7	7	23	26	52	0.3	1	0.26	86.4	6.6219	1.5398
2015	7	7	23	36	52	0.3	1	0.21	95.4	6.6219	1.2319
2015	7	7	23	46	52	0.3	1	0.16	65	6.6219	0.8661
2015	7	7	23	56	52	0.3	1	0.21	98.9	6.6219	1.2319
2015	7	8	0	6	52	0.3	1	0.24	90.8	6.6219	1.4051
2015	7	8	0	16	52	0.3	1	0.21	99.2	6.6219	1.1934
2015	7	8	0	26	52	0.3	1	0.19	96.9	6.6219	1.1164
2015	7	8	0	36	52	0.3	1	0.24	90	6.6219	1.3859
2015	7	8	0	46	52	0.3	1	0.2	79.6	6.6413	1.1585
2015	7	8	0	56	52	0.3	1	0.26	90	6.6219	1.5206
2015	7	8	1	6	52	0.3	1	0.22	91.7	6.6219	1.2896
2015	7	8	1	16	52	0.3	1	0.24	105.2	6.6413	1.3516
2015	7	8	1	26	52	0.3	1	0.21	90	6.6219	1.2511
2015	7	8	1	36	52	0.3	1	0.24	89.2	6.6413	1.3902
2015	7	8	1	46	52	0.3	1	0.21	82.6	6.6219	1.1934
2015	7	8	1	56	52	0.3	1	0.16	86.6	6.6413	0.9654

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	8	2	6	52	0.3	1	0.27	111	6.6219	1.5014
2015	7	8	2	16	52	0.3	1	0.24	96.3	6.6413	1.3902
2015	7	8	2	26	52	0.3	1	0.22	86.6	6.6413	1.2937
2015	7	8	2	36	52	0.3	1	0.25	90	6.6413	1.4675
2015	7	8	2	46	52	0.3	1	0.3	100.2	6.6413	1.7185
2015	7	8	2	56	52	0.3	1	0.23	87.6	6.6413	1.3709
2015	7	8	3	6	52	0.3	1	0.23	85	6.6413	1.3323
2015	7	8	3	16	52	0.3	1	0.2	85.2	6.6413	1.1585
2015	7	8	3	26	52	0.3	1	0.18	93.1	6.6413	1.062
2015	7	8	3	36	52	0.3	1	0.19	99.1	6.6413	1.0813
2015	7	8	3	46	52	0.3	1	0.21	95.3	6.6413	1.2551
2015	7	8	3	56	52	0.3	1	0.18	97.5	6.6413	1.0234
2015	7	8	4	6	52	0.3	1	0.27	88.6	6.6413	1.5833
2015	7	8	4	16	52	0.3	1	0.22	96.1	6.6413	1.2744
2015	7	8	4	26	52	0.3	1	0.18	91.1	6.6413	1.0427
2015	7	8	4	36	52	0.3	1	0.3	93.8	6.6413	1.7378
2015	7	8	4	46	52	0.3	1	0.24	112.1	6.6413	1.3323
2015	7	8	4	56	52	0.3	1	0.19	103.3	6.6413	1.062
2015	7	8	5	6	52	0.3	1	0.26	92.2	6.6413	1.5254
2015	7	8	5	16	52	0.3	1	0.2	101.1	6.6413	1.1778
2015	7	8	5	26	52	0.3	1	0.23	86	6.6413	1.3709
2015	7	8	5	36	52	0.3	1	0.25	86.2	6.6413	1.4675
2015	7	8	5	46	52	0.3	1	0.21	106.7	6.6413	1.1585
2015	7	8	5	56	52	0.3	1	0.26	96.6	6.6413	1.5061
2015	7	8	6	6	52	0.3	1	0.2	109.9	6.6413	1.1199
2015	7	8	6	16	52	0.3	1	0.18	108.1	6.6607	1.0072
2015	7	8	6	26	52	0.3	1	0.19	99.1	6.6607	1.0847
2015	7	8	6	36	52	0.3	1	0.21	83.9	6.6607	1.259
2015	7	8	6	46	52	0.3	1	0.15	90	6.6607	0.891
2015	7	8	6	56	52	0.3	1	0.22	84.8	6.6607	1.2784
2015	7	8	7	6	52	0.3	1	0.25	94.6	6.6607	1.4527
2015	7	8	7	16	52	0.3	1	0.29	90.6	6.6607	1.7239
2015	7	8	7	26	52	0.3	1	0.24	77.5	6.6607	1.3946
2015	7	8	7	36	52	0.3	1	0.27	72.4	6.6607	1.5302

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	8	7	46	52	0.3	1	0.24	106.2	6.6607	1.3365
2015	7	8	7	56	52	0.3	1	0.25	102	6.6607	1.4527
2015	7	8	8	6	52	0.3	1	0.2	82.4	6.6607	1.1622
2015	7	8	8	16	52	0.3	1	0.21	77.1	6.6607	1.1815
2015	7	8	8	26	52	0.3	1	0.23	85.9	6.6607	1.3365
2015	7	8	8	36	52	0.3	1	0.3	87.5	6.6607	1.782
2015	7	8	8	46	52	0.3	1	0.19	98	6.6607	1.1041
2015	7	8	8	56	52	0.3	1	0.24	108.7	6.6607	1.3171
2015	7	8	9	6	52	0.3	1	0.2	92.8	6.6607	1.2009
2015	7	8	9	16	52	0.3	1	0.23	120.7	6.6607	1.1428
2015	7	8	9	26	52	0.3	1	0.16	99.3	6.6607	0.9491
2015	7	8	9	36	52	0.3	1	0.2	96.5	6.6607	1.1815
2015	7	8	9	46	52	0.3	1	0.22	110.9	6.6607	1.2203
2015	7	8	9	56	52	0.3	1	0.28	98	6.6607	1.6464
2015	7	8	10	6	52	0.3	1	0.19	73.8	6.6607	1.0653
2015	7	8	10	16	52	0.3	1	0.22	80.4	6.6607	1.259
2015	7	8	10	26	52	0.3	1	0.25	78.1	6.6607	1.4721
2015	7	8	10	36	52	0.3	1	0.22	81.4	6.6607	1.2784
2015	7	8	10	46	52	0.3	1	0.18	77.2	6.6607	1.0266
2015	7	8	10	56	52	0.3	1	0.24	86.9	6.6607	1.4139
2015	7	8	11	6	52	0.3	1	0.23	85.9	6.6607	1.3558
2015	7	8	11	16	52	0.3	1	0.22	76.2	6.6607	1.259
2015	7	8	11	26	52	0.3	1	0.16	68.2	6.6607	0.8716
2015	7	8	11	36	52	0.3	1	0.19	96	6.6607	1.104
2015	7	8	11	46	52	0.3	1	0.2	68.6	6.6607	1.0847
2015	7	8	11	56	52	0.3	1	0.23	89.2	6.6607	1.3365
2015	7	8	12	6	52	0.3	1	0.21	62.6	6.6607	1.0847
2015	7	8	12	16	52	0.3	1	0.3	78.7	6.6607	1.7432
2015	7	8	12	26	52	0.3	1	0.21	70.4	6.6413	1.1392
2015	7	8	12	36	52	0.3	1	0.27	76.1	6.6607	1.5689
2015	7	8	12	46	52	0.3	1	0.24	70.1	6.6607	1.3364
2015	7	8	12	56	52	0.3	1	0.23	66.4	6.6607	1.2396
2015	7	8	13	6	52	0.3	1	0.23	74.4	6.6607	1.3171
2015	7	8	13	16	52	0.3	1	0.19	56.9	6.6413	0.9461

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	8	13	26	52	0.3	1	0.24	71.6	6.6607	1.3364
2015	7	8	13	36	52	0.3	1	0.25	68.2	6.6607	1.3558
2015	7	8	13	46	52	0.3	1	0.28	76	6.6607	1.6269
2015	7	8	13	56	52	0.3	1	0.24	69.6	6.6607	1.3558
2015	7	8	14	6	52	0.3	1	0.19	88	6.6607	1.104
2015	7	8	14	16	52	0.3	1	0.28	82.6	6.6413	1.6412
2015	7	8	14	26	52	0.3	1	0.28	81.9	6.6607	1.6269
2015	7	8	14	36	52	0.3	1	0.21	82.8	6.6607	1.2202
2015	7	8	14	46	52	0.3	1	0.26	85	6.6607	1.5495
2015	7	8	14	56	52	0.3	1	0.27	82.4	6.6607	1.5882
2015	7	8	15	6	52	0.3	1	0.27	74.6	6.6413	1.5446
2015	7	8	15	16	52	0.3	1	0.26	92.1	6.6607	1.5495
2015	7	8	15	26	52	0.3	1	0.26	80	6.6413	1.5253
2015	7	8	15	36	52	0.3	1	0.25	73.7	6.6607	1.3945
2015	7	8	15	46	52	0.3	1	0.15	62.9	6.6413	0.7916
2015	7	8	15	56	52	0.3	1	0.29	81.4	6.6607	1.6657
2015	7	8	16	6	52	0.3	1	0.27	97	6.6413	1.5639
2015	7	8	16	16	52	0.3	1	0.22	61.2	6.6413	1.1585
2015	7	8	16	26	52	0.3	1	0.26	90.7	6.6413	1.506
2015	7	8	16	36	52	0.3	1	0.23	66	6.6413	1.255
2015	7	8	16	46	52	0.3	1	0.24	90	6.6413	1.4288
2015	7	8	16	56	52	0.3	1	0.16	102.9	6.6413	0.9268
2015	7	8	17	6	52	0.3	1	0.23	90	6.6413	1.3322
2015	7	8	17	16	52	0.3	1	0.27	87.2	6.6413	1.5832
2015	7	8	17	26	52	0.3	1	0.25	103.9	6.6413	1.4095
2015	7	8	17	36	52	0.3	1	0.26	97.8	6.6413	1.5446
2015	7	8	17	46	52	0.3	1	0.23	101.3	6.6413	1.3516
2015	7	8	17	56	52	0.3	1	0.23	95.8	6.6413	1.3322
2015	7	8	18	6	52	0.3	1	0.23	102.3	6.6413	1.3322
2015	7	8	18	16	52	0.3	1	0.23	94.1	6.6413	1.3322
2015	7	8	18	26	52	0.3	1	0.21	93.5	6.6413	1.255
2015	7	8	18	36	52	0.3	1	0.22	82.1	6.6413	1.255
2015	7	8	18	46	52	0.3	1	0.22	85.7	6.6413	1.2936
2015	7	8	18	56	52	0.3	1	0.23	104	6.6413	1.3129

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	8	19	6	52	0.3	1	0.23	89.2	6.6413	1.3709
2015	7	8	19	16	52	0.3	1	0.23	76.6	6.6219	1.2896
2015	7	8	19	26	52	0.3	1	0.25	84.8	6.6219	1.4821
2015	7	8	19	36	52	0.3	1	0.23	80.8	6.6219	1.3089
2015	7	8	19	46	52	0.3	1	0.12	72.1	6.6219	0.6544
2015	7	8	19	56	52	0.3	1	0.22	91.7	6.6219	1.2896
2015	7	8	20	6	52	0.3	1	0.21	90.9	6.6219	1.2319
2015	7	8	20	16	52	0.3	1	0.18	84.8	6.6219	1.0586
2015	7	8	20	26	52	0.3	1	0.19	108.4	6.6219	1.0394
2015	7	8	20	36	52	0.3	1	0.26	87.8	6.6219	1.5206
2015	7	8	20	46	52	0.3	1	0.27	98.3	6.6219	1.5783
2015	7	8	20	56	52	0.3	1	0.25	84.8	6.6219	1.4821
2015	7	8	21	6	52	0.3	1	0.2	94.6	6.6219	1.1934
2015	7	8	21	16	52	0.3	1	0.14	69	6.6219	0.7507
2015	7	8	21	26	52	0.3	1	0.2	68.6	6.6219	1.0779
2015	7	8	21	36	52	0.3	1	0.2	80.7	6.6219	1.1741
2015	7	8	21	46	52	0.3	1	0.17	105.9	6.6219	0.9432
2015	7	8	21	56	52	0.3	1	0.22	81.4	6.6026	1.2664
2015	7	8	22	6	52	0.3	1	0.28	78.4	6.6219	1.5976
2015	7	8	22	16	52	0.3	1	0.18	85.9	6.6026	1.0745
2015	7	8	22	26	52	0.3	1	0.22	90	6.6026	1.2856
2015	7	8	22	36	52	0.3	1	0.23	78.7	6.6219	1.3474
2015	7	8	22	46	52	0.3	1	0.19	90	6.6026	1.1129
2015	7	8	22	56	52	0.3	1	0.19	106.2	6.6026	1.0554
2015	7	8	23	6	52	0.3	1	0.26	77.6	6.6026	1.4775
2015	7	8	23	16	52	0.3	1	0.18	108.1	6.6026	0.9978
2015	7	8	23	26	52	0.3	1	0.24	93.1	6.6026	1.4008
2015	7	8	23	36	52	0.3	1	0.24	98.8	6.6026	1.3624
2015	7	8	23	46	52	0.3	1	0.18	78.7	6.6026	1.0554
2015	7	8	23	56	52	0.3	1	0.15	88.8	6.6026	0.9019
2015	7	9	0	6	52	0.3	1	0.26	76.1	6.6026	1.4775
2015	7	9	0	16	52	0.3	1	0.21	92.6	6.6026	1.2473
2015	7	9	0	26	52	0.3	1	0.22	97.8	6.6026	1.2665
2015	7	9	0	36	52	0.3	1	0.24	85.4	6.6026	1.42

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	9	0	46	52	0.3	1	0.18	86.8	6.6026	1.0362
2015	7	9	0	56	52	0.3	1	0.13	90	6.6026	0.7867
2015	7	9	1	6	52	0.3	1	0.19	100	6.6026	1.0938
2015	7	9	1	16	52	0.3	1	0.24	96.3	6.6026	1.3816
2015	7	9	1	26	52	0.3	1	0.23	89.2	6.6026	1.3432
2015	7	9	1	36	52	0.3	1	0.2	104.9	6.6026	1.1513
2015	7	9	1	46	52	0.3	1	0.23	101.6	6.6026	1.3048
2015	7	9	1	56	52	0.3	1	0.22	90	6.6026	1.2665
2015	7	9	2	6	52	0.3	1	0.24	103.7	6.6026	1.3432
2015	7	9	2	16	52	0.3	1	0.2	66.8	6.6026	1.0746
2015	7	9	2	26	52	0.3	1	0.25	90.7	6.6026	1.4776
2015	7	9	2	36	52	0.3	1	0.27	91.4	6.6026	1.5543
2015	7	9	2	46	52	0.3	1	0.18	90	6.6026	1.0362
2015	7	9	2	56	52	0.3	1	0.19	85.2	6.6026	1.1322
2015	7	9	3	6	52	0.3	1	0.18	85.9	6.6026	1.0746
2015	7	9	3	16	52	0.3	1	0.28	89.3	6.6026	1.6119
2015	7	9	3	26	52	0.3	1	0.23	104	6.6026	1.3049
2015	7	9	3	36	52	0.3	1	0.18	74.5	6.6026	1.0362
2015	7	9	3	46	52	0.3	1	0.17	91.1	6.6026	0.9978
2015	7	9	3	56	52	0.3	1	0.25	101.9	6.6026	1.4584
2015	7	9	4	6	52	0.3	1	0.23	90.8	6.6026	1.3241
2015	7	9	4	16	52	0.3	1	0.17	98.7	6.6026	0.9978
2015	7	9	4	26	52	0.3	1	0.24	81.3	6.6026	1.3816
2015	7	9	4	36	52	0.3	1	0.2	94.8	6.6026	1.1514
2015	7	9	4	46	52	0.3	1	0.23	90	6.6026	1.3241
2015	7	9	4	56	52	0.3	1	0.22	90	6.6026	1.3049
2015	7	9	5	6	52	0.3	1	0.24	104	6.6026	1.3816
2015	7	9	5	16	52	0.3	1	0.27	88.6	6.6026	1.5543
2015	7	9	5	26	52	0.3	1	0.24	106.2	6.6026	1.3241
2015	7	9	5	36	52	0.3	1	0.17	91.1	6.6026	0.9979
2015	7	9	5	46	52	0.3	1	0.25	106	6.6026	1.4008
2015	7	9	5	56	52	0.3	1	0.2	87.2	6.6026	1.1897
2015	7	9	6	6	52	0.3	1	0.28	92	6.6026	1.6119
2015	7	9	6	16	52	0.3	1	0.2	92.8	6.6026	1.1897

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	9	6	26	52	0.3	1	0.27	82.4	6.6026	1.5735
2015	7	9	6	36	52	0.3	1	0.15	99	6.6026	0.8443
2015	7	9	6	46	52	0.3	1	0.22	115.4	6.6026	1.1706
2015	7	9	6	56	52	0.3	1	0.18	76	6.6026	0.9979
2015	7	9	7	6	52	0.3	1	0.18	101.7	6.6026	1.017
2015	7	9	7	16	52	0.3	1	0.23	99.2	6.6026	1.3049
2015	7	9	7	26	52	0.3	1	0.17	100	6.6026	0.9787
2015	7	9	7	36	52	0.3	1	0.2	102.6	6.6026	1.113
2015	7	9	7	46	52	0.3	1	0.14	122.2	6.6026	0.6716
2015	7	9	7	56	52	0.3	1	0.24	98.8	6.6026	1.3625
2015	7	9	8	6	52	0.3	1	0.17	111	6.6026	0.9019
2015	7	9	8	16	52	0.3	1	0.23	107.7	6.6026	1.2665
2015	7	9	8	26	52	0.3	1	0.23	122.3	6.6026	1.1514
2015	7	9	8	36	52	0.3	1	0.19	101.1	6.6026	1.0746
2015	7	9	8	46	52	0.3	1	0.14	74.6	6.6026	0.7676
2015	7	9	8	56	52	0.3	1	0.18	108.4	6.6026	0.9787
2015	7	9	9	6	52	0.3	1	0.13	111.3	6.6026	0.6908
2015	7	9	9	16	52	0.3	1	0.23	89.2	6.6026	1.3241
2015	7	9	9	26	52	0.3	1	0.25	96.1	6.6026	1.4392
2015	7	9	9	36	52	0.3	1	0.23	71.1	6.6026	1.2857
2015	7	9	9	46	52	0.3	1	0.38	66.1	6.6219	2.0405
2015	7	9	9	56	52	0.3	1	0.37	63.2	6.6026	1.9381
2015	7	9	10	6	52	0.3	1	0.19	81.2	6.6026	1.113
2015	7	9	10	16	52	0.3	1	0.2	168.5	6.6026	0.2303
2015	7	9	10	26	52	0.3	1	0.2	151.3	6.6026	0.5565
2015	7	9	10	36	52	0.3	1	0.15	151.8	6.6026	0.4222
2015	7	9	10	46	52	0.3	1	0.25	74.9	6.6026	1.42
2015	7	9	10	56	52	0.3	1	0.2	98.7	6.6026	1.1322
2015	7	9	11	6	52	0.3	1	0.16	105.2	6.6026	0.9211
2015	7	9	11	16	52	0.3	1	0.18	90	6.6026	1.0746
2015	7	9	11	26	52	0.3	1	0.2	115.7	6.6026	1.0746
2015	7	9	11	36	52	0.3	1	0.22	82.2	6.6026	1.2665
2015	7	9	11	46	52	0.3	1	0.23	66.7	6.5252	1.2316
2015	7	9	11	56	52	0.3	1	0.27	58.1	6.5832	1.3199

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	9	12	6	52	0.3	1	0.31	52.7	6.6026	1.4584
2015	7	9	12	16	52	0.3	1	0.27	64.4	6.5832	1.4347
2015	7	9	12	26	52	0.3	1	0.2	54.8	6.5832	0.9756
2015	7	9	12	36	52	0.3	1	0.31	44.1	6.5832	1.2434
2015	7	9	12	46	52	0.3	1	0.31	43.3	6.5832	1.2434
2015	7	9	12	56	52	0.3	1	0.32	40.4	6.5832	1.2051
2015	7	9	13	6	52	0.3	1	0.3	43.2	6.5832	1.2051
2015	7	9	13	16	52	0.3	1	0.36	39.4	6.5832	1.3199
2015	7	9	13	26	52	0.3	1	0.33	48.2	6.5832	1.4347
2015	7	9	13	36	52	0.3	1	0.27	49.9	6.5832	1.2051
2015	7	9	13	46	52	0.3	1	0.3	45	6.5832	1.2243
2015	7	9	13	56	52	0.3	1	0.38	44.3	6.5832	1.5494
2015	7	9	14	6	52	0.3	1	0.32	30	6.5832	0.9373
2015	7	9	14	16	52	0.3	1	0.27	37.6	6.5832	0.9564
2015	7	9	14	26	52	0.3	1	0.23	43.9	6.5832	0.9373
2015	7	9	14	36	52	0.3	1	0.37	36.7	6.5832	1.2816
2015	7	9	14	46	52	0.3	1	0.31	36.3	6.5832	1.0521
2015	7	9	14	56	52	0.3	1	0.33	28.1	6.5832	0.9182
2015	7	9	15	6	52	0.3	1	0.34	23.3	6.5832	0.7843
2015	7	9	15	16	52	0.3	1	0.32	32.6	6.5832	1.0138
2015	7	9	15	26	52	0.3	1	0.36	31.8	6.5639	1.0869
2015	7	9	15	36	52	0.3	1	0.43	32.7	6.5639	1.3348
2015	7	9	15	46	52	0.3	1	0.37	40.3	6.5639	1.392
2015	7	9	15	56	52	0.3	1	0.37	33.4	6.5639	1.1822
2015	7	9	16	6	52	0.3	1	0.38	30.1	6.5639	1.106
2015	7	9	16	16	52	0.3	1	0.28	32	6.5639	0.8581
2015	7	9	16	26	52	0.3	1	0.32	35.9	6.5639	1.106
2015	7	9	16	36	52	0.3	1	0.3	38.3	6.5639	1.0678
2015	7	9	16	46	52	0.3	1	0.33	23.5	6.5639	0.7627
2015	7	9	16	56	52	0.3	1	0.32	31.6	6.5639	0.9725
2015	7	9	17	6	52	0.3	1	0.25	50.8	6.5639	1.1441
2015	7	9	17	16	52	0.3	1	0.35	33.2	6.5639	1.125
2015	7	9	17	26	52	0.3	1	0.32	38	6.5639	1.1632
2015	7	9	17	36	52	0.3	1	0.34	28.6	6.5639	0.9343

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	9	17	46	52	0.3	1	0.34	43.5	6.5639	1.3729
2015	7	9	17	56	52	0.3	1	0.31	27.9	6.5639	0.839
2015	7	9	18	6	52	0.3	1	0.3	57.2	6.5639	1.4492
2015	7	9	18	16	52	0.3	1	0.3	65.7	6.5639	1.5636
2015	7	9	18	26	52	0.3	1	0.21	43.8	6.5639	0.8581
2015	7	9	18	36	52	0.3	1	0.29	40.5	6.5639	1.106
2015	7	9	18	46	52	0.3	1	0.26	66.3	6.5639	1.392
2015	7	9	18	56	52	0.3	1	0.24	64.1	6.5639	1.2585
2015	7	9	19	6	52	0.3	1	0.2	65.6	6.5445	1.0454
2015	7	9	19	16	52	0.3	1	0.23	75.4	6.5639	1.3157
2015	7	9	19	26	52	0.3	1	0.19	68.4	6.5639	1.0106
2015	7	9	19	36	52	0.3	1	0.1	80.8	6.5639	0.5911
2015	7	9	19	46	52	0.3	1	0.1	60	6.5639	0.4958
2015	7	9	19	56	52	0.3	1	0.15	58	6.5639	0.7627
2015	7	9	20	6	52	0.3	1	0.22	69.1	6.5639	1.2013
2015	7	9	20	16	52	0.3	1	0.21	97	6.5445	1.2355
2015	7	9	20	26	52	0.3	1	0.23	90.8	6.5639	1.3157
2015	7	9	20	36	52	0.3	1	0.18	97.5	6.5639	1.0106
2015	7	9	20	46	52	0.3	1	0.19	81.2	6.5639	1.106
2015	7	9	20	56	52	0.3	1	0.24	98.6	6.5445	1.3876
2015	7	9	21	6	52	0.3	1	0.2	102.4	6.5445	1.1215
2015	7	9	21	16	52	0.3	1	0.24	90	6.5445	1.3686
2015	7	9	21	26	52	0.3	1	0.18	69	6.5639	0.9916
2015	7	9	21	36	52	0.3	1	0.24	86.1	6.5445	1.4066
2015	7	9	21	46	52	0.3	1	0.23	111	6.5639	1.2395
2015	7	9	21	56	52	0.3	1	0.19	105.9	6.5445	1.0645
2015	7	9	22	6	52	0.3	1	0.21	85.5	6.5445	1.2165
2015	7	9	22	16	52	0.3	1	0.12	73.6	6.5639	0.6483
2015	7	9	22	26	52	0.3	1	0.23	65.2	6.5639	1.2395
2015	7	9	22	36	52	0.3	1	0.2	74.8	6.5639	1.125
2015	7	9	22	46	52	0.3	1	0.12	97.7	6.5639	0.7055
2015	7	9	22	56	52	0.3	1	0.21	70.7	6.5639	1.1441
2015	7	9	23	6	52	0.3	1	0.25	65.8	6.5639	1.3157
2015	7	9	23	16	52	0.3	1	0.23	94.1	6.5639	1.3157

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	9	23	26	52	0.3	1	0.25	74.2	6.5639	1.4111
2015	7	9	23	36	52	0.3	1	0.19	80.2	6.5639	1.106
2015	7	9	23	46	52	0.3	1	0.2	80.7	6.5639	1.1632
2015	7	9	23	56	52	0.3	1	0.21	98	6.5445	1.2165
2015	7	10	0	6	52	0.3	1	0.18	83.8	6.5445	1.0455
2015	7	10	0	16	52	0.3	1	0.22	76	6.5445	1.2165
2015	7	10	0	26	52	0.3	1	0.19	90	6.5639	1.1251
2015	7	10	0	36	52	0.3	1	0.18	96.2	6.5445	1.0455
2015	7	10	0	46	52	0.3	1	0.21	98	6.5445	1.2165
2015	7	10	0	56	52	0.3	1	0.21	82	6.5445	1.2165
2015	7	10	1	6	52	0.3	1	0.22	98.5	6.5445	1.2736
2015	7	10	1	16	52	0.3	1	0.23	99.2	6.5445	1.2926
2015	7	10	1	26	52	0.3	1	0.17	92.2	6.5445	0.9694
2015	7	10	1	36	52	0.3	1	0.22	78	6.5445	1.2546
2015	7	10	1	46	52	0.3	1	0.15	111.1	6.5445	0.8364
2015	7	10	1	56	52	0.3	1	0.19	84	6.5445	1.0835
2015	7	10	2	6	52	0.3	1	0.24	110.6	6.5445	1.3116
2015	7	10	2	16	52	0.3	1	0.18	84.8	6.5445	1.0455
2015	7	10	2	26	52	0.3	1	0.22	74.5	6.5445	1.2356
2015	7	10	2	36	52	0.3	1	0.16	109.6	6.5445	0.8554
2015	7	10	2	46	52	0.3	1	0.21	65.9	6.5445	1.1025
2015	7	10	2	56	52	0.3	1	0.26	104	6.5445	1.4447
2015	7	10	3	6	52	0.3	1	0.12	122.8	6.5445	0.5893
2015	7	10	3	16	52	0.3	1	0.17	85.7	6.5445	1.0075
2015	7	10	3	26	52	0.3	1	0.19	93	6.5445	1.1025
2015	7	10	3	36	52	0.3	1	0.17	82.2	6.5445	0.9694
2015	7	10	3	46	52	0.3	1	0.17	90	6.5445	0.9885
2015	7	10	3	56	52	0.3	1	0.2	109.3	6.5445	1.0835
2015	7	10	4	6	52	0.3	1	0.15	86.2	6.5445	0.8554
2015	7	10	4	16	52	0.3	1	0.23	81.9	6.5445	1.3306
2015	7	10	4	26	52	0.3	1	0.12	112.4	6.5445	0.6463
2015	7	10	4	36	52	0.3	1	0.19	96.9	6.5445	1.1025
2015	7	10	4	46	52	0.3	1	0.17	121.5	6.5445	0.8364
2015	7	10	4	56	52	0.3	1	0.2	73.7	6.5445	1.1025

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	10	5	6	52	0.3	1	0.22	88.3	6.5445	1.2546
2015	7	10	5	16	52	0.3	1	0.14	83	6.5252	0.7769
2015	7	10	5	26	52	0.3	1	0.21	90	6.5252	1.2317
2015	7	10	5	36	52	0.3	1	0.21	101.8	6.5252	1.1748
2015	7	10	5	46	52	0.3	1	0.16	87.7	6.5252	0.9285
2015	7	10	5	56	52	0.3	1	0.17	99.1	6.5252	0.9474
2015	7	10	6	6	52	0.3	1	0.26	95.1	6.5252	1.4969
2015	7	10	6	16	52	0.3	1	0.25	92.3	6.5252	1.4211
2015	7	10	6	26	52	0.3	1	0.12	105.5	6.5252	0.6822
2015	7	10	6	36	52	0.3	1	0.15	90	6.5252	0.8906
2015	7	10	6	46	52	0.3	1	0.19	87	6.5252	1.0801
2015	7	10	6	56	52	0.3	1	0.18	78.3	6.5252	1.0043
2015	7	10	7	6	52	0.3	1	0.12	107	6.5252	0.6822
2015	7	10	7	16	52	0.3	1	0.14	76.9	6.5252	0.8148
2015	7	10	7	26	52	0.3	1	0.19	75	6.5252	1.0611
2015	7	10	7	36	52	0.3	1	0.33	70.7	6.5252	1.7812
2015	7	10	7	46	52	0.3	1	0.18	101.7	6.5252	1.0043
2015	7	10	7	56	52	0.3	1	0.28	75.2	6.5252	1.5727
2015	7	10	8	6	52	0.3	1	0.24	83	6.5252	1.3832
2015	7	10	8	16	52	0.3	1	0.1	120.7	6.5252	0.5116
2015	7	10	8	26	52	0.3	1	0.29	59.7	6.5058	1.4544
2015	7	10	8	36	52	0.3	1	0.16	141	6.5058	0.5666
2015	7	10	8	46	52	0.3	1	0.15	125.1	6.5058	0.6989
2015	7	10	8	56	52	0.3	1	0.08	145	6.5058	0.2644
2015	7	10	9	6	52	0.3	1	0.15	103.7	6.5058	0.85
2015	7	10	9	16	52	0.3	1	0.27	69.1	6.5058	1.4355
2015	7	10	9	26	52	0.3	1	0.2	46.3	6.5058	0.85
2015	7	10	9	36	52	0.3	1	0.18	105.8	6.5058	1.0011
2015	7	10	9	46	52	0.3	1	0.16	81.7	6.5058	0.9066
2015	7	10	9	56	52	0.3	1	0.16	53.1	6.5252	0.7579
2015	7	10	10	6	52	0.3	1	0.26	59.9	6.5445	1.3116
2015	7	10	10	16	52	0.3	1	0.19	70.6	6.5058	1.0199
2015	7	10	10	26	52	0.3	1	0.24	64.8	6.4864	1.2426
2015	7	10	10	36	52	0.3	1	0.18	76.5	6.4864	1.0167

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	10	10	46	52	0.3	1	0.23	83.4	6.4671	1.2949
2015	7	10	10	56	52	0.3	1	0.14	56.3	6.4671	0.6756
2015	7	10	11	6	52	0.3	1	0.12	85.4	6.4671	0.6944
2015	7	10	11	16	52	0.3	1	0.17	90	6.4477	0.954
2015	7	10	11	26	52	0.3	1	0.2	47	6.4477	0.8418
2015	7	10	11	36	52	0.3	1	0.17	66.9	6.4477	0.8792
2015	7	10	11	46	52	0.3	1	0.26	60.8	6.4477	1.272
2015	7	10	11	56	52	0.3	1	0.19	60.3	6.4284	0.9137
2015	7	10	12	6	52	0.3	1	0.22	82.1	6.4284	1.212
2015	7	10	12	16	52	0.3	1	0.22	56.1	6.4284	1.0255
2015	7	10	12	26	52	0.3	1	0.18	70.9	6.4284	0.9696
2015	7	10	12	36	52	0.3	1	0.21	83.9	6.4284	1.212
2015	7	10	12	46	52	0.3	1	0.26	69.7	6.4477	1.3656
2015	7	10	12	56	52	0.3	1	0.18	58.9	6.4284	0.895
2015	7	10	13	6	52	0.3	1	0.11	79.4	6.4284	0.5967
2015	7	10	13	16	52	0.3	1	0.23	62.7	6.4284	1.156
2015	7	10	13	26	52	0.3	1	0.14	35.2	6.4284	0.4475
2015	7	10	13	36	52	0.3	1	0.22	65.3	6.4284	1.1374
2015	7	10	13	46	52	0.3	1	0.17	41	6.4284	0.6153
2015	7	10	13	56	52	0.3	1	0.27	62.8	6.4284	1.3425
2015	7	10	14	6	52	0.3	1	0.19	80.9	6.4284	1.0441
2015	7	10	14	16	52	0.3	1	0.15	77.2	6.4284	0.8204
2015	7	10	14	26	52	0.3	1	0.18	73.5	6.4284	1.0068
2015	7	10	14	36	52	0.3	1	0.16	70.4	6.4284	0.839
2015	7	10	14	46	52	0.3	1	0.13	52	6.409	0.5947
2015	7	10	14	56	52	0.3	1	0.24	93.1	6.4284	1.3611
2015	7	10	15	6	52	0.3	1	0.29	56	6.4284	1.3797
2015	7	10	15	16	52	0.3	1	0.17	77.6	6.4284	0.9323
2015	7	10	15	26	52	0.3	1	0.16	76.8	6.409	0.8735
2015	7	10	15	36	52	0.3	1	0.21	68.2	6.409	1.1151
2015	7	10	15	46	52	0.3	1	0.11	84.8	6.409	0.6133
2015	7	10	15	56	52	0.3	1	0.16	106.9	6.409	0.8549
2015	7	10	16	6	52	0.3	1	0.19	85.1	6.409	1.0779
2015	7	10	16	16	52	0.3	1	0.16	66	6.409	0.8363

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	10	16	26	52	0.3	1	0.22	81.5	6.3897	1.2412
2015	7	10	16	36	52	0.3	1	0.14	77.6	6.3897	0.7595
2015	7	10	16	46	52	0.3	1	0.15	59.5	6.3703	0.7201
2015	7	10	16	56	52	0.3	1	0.17	54.2	6.3897	0.7966
2015	7	10	17	6	52	0.3	1	0.27	62.2	6.3897	1.3338
2015	7	10	17	16	52	0.3	1	0.23	59.5	6.3897	1.13
2015	7	10	17	26	52	0.3	1	0.13	31.2	6.3897	0.3705
2015	7	10	17	36	52	0.3	1	0.28	36.9	6.409	0.9478
2015	7	10	17	46	52	0.3	1	0.33	53.5	6.3897	1.5005
2015	7	10	17	56	52	0.3	1	0.26	54.9	6.409	1.1894
2015	7	10	18	6	52	0.3	1	0.23	67.4	6.409	1.208
2015	7	10	18	16	52	0.3	1	0.26	36.1	6.409	0.8549
2015	7	10	18	26	52	0.3	1	0.15	73.9	6.409	0.8363
2015	7	10	18	36	52	0.3	1	0.23	45.6	6.409	0.9292
2015	7	10	18	46	52	0.3	1	0.22	68.8	6.409	1.1523
2015	7	10	18	56	52	0.3	1	0.18	55.4	6.3897	0.8336
2015	7	10	19	6	52	0.3	1	0.16	85.4	6.409	0.9292
2015	7	10	19	16	52	0.3	1	0.06	78.1	6.409	0.3531
2015	7	10	19	26	52	0.3	1	0.16	87.7	6.409	0.9293
2015	7	10	19	36	52	0.3	1	0.11	100.6	6.409	0.5947
2015	7	10	19	46	52	0.3	1	0.12	76	6.409	0.6691
2015	7	10	19	56	52	0.3	1	0.2	60.9	6.3897	1.0003
2015	7	10	20	6	52	0.3	1	0.12	98.1	6.3897	0.6484
2015	7	10	20	16	52	0.3	1	0.22	50.9	6.3897	0.9818
2015	7	10	20	26	52	0.3	1	0.19	59.9	6.3897	0.9262
2015	7	10	20	36	52	0.3	1	0.27	48	6.3897	1.13
2015	7	10	20	46	52	0.3	1	0.13	66	6.3897	0.6669
2015	7	10	20	56	52	0.3	1	0.24	47.2	6.3897	1.0003
2015	7	10	21	6	52	0.3	1	0.16	53.1	6.3897	0.741
2015	7	10	21	16	52	0.3	1	0.18	60.1	6.3897	0.8707
2015	7	10	21	26	52	0.3	1	0.24	58.2	6.3897	1.1671
2015	7	10	21	36	52	0.3	1	0.24	40.6	6.3897	0.8892
2015	7	10	21	46	52	0.3	1	0.24	30.7	6.3897	0.704
2015	7	10	21	56	52	0.3	1	0.29	43.2	6.3897	1.13

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	10	22	6	52	0.3	1	0.27	43.5	6.3897	1.0559
2015	7	10	22	16	52	0.3	1	0.25	45	6.3897	0.9818
2015	7	10	22	26	52	0.3	1	0.24	31.5	6.3897	0.704
2015	7	10	22	36	52	0.3	1	0.15	54.6	6.3897	0.704
2015	7	10	22	46	52	0.3	1	0.12	77.8	6.3897	0.6854
2015	7	10	22	56	52	0.3	1	0.25	59.4	6.3897	1.2227
2015	7	10	23	6	52	0.3	1	0.19	47.1	6.3897	0.7966
2015	7	10	23	16	52	0.3	1	0.22	79	6.3897	1.2412
2015	7	10	23	26	52	0.3	1	0.16	80.7	6.3897	0.9077
2015	7	10	23	36	52	0.3	1	0.18	71.6	6.3897	0.9448
2015	7	10	23	46	52	0.3	1	0.15	97.4	6.3897	0.8522
2015	7	10	23	56	52	0.3	1	0.13	41.9	6.3897	0.4817
2015	7	11	0	6	52	0.3	1	0.1	84.3	6.3897	0.5558
2015	7	11	0	16	52	0.3	1	0.11	100.6	6.3897	0.5928
2015	7	11	0	26	52	0.3	1	0.09	79.9	6.3897	0.5187
2015	7	11	0	36	52	0.3	1	0.13	70.6	6.3897	0.6854
2015	7	11	0	46	52	0.3	1	0.22	85.7	6.3897	1.2227
2015	7	11	0	56	52	0.3	1	0.14	79.5	6.3897	0.7966
2015	7	11	1	6	52	0.3	1	0.21	117.4	6.3897	1.0374
2015	7	11	1	16	52	0.3	1	0.14	90	6.3897	0.8151
2015	7	11	1	26	52	0.3	1	0.12	85.4	6.3897	0.6854
2015	7	11	1	36	52	0.3	1	0.16	102.9	6.3897	0.8892
2015	7	11	1	46	52	0.3	1	0.07	90	6.3897	0.389
2015	7	11	1	56	52	0.3	1	0.17	98.7	6.3897	0.9633
2015	7	11	2	6	52	0.3	1	0.14	87.3	6.3897	0.7966
2015	7	11	2	16	52	0.3	1	0.16	120.2	6.3897	0.7966
2015	7	11	2	26	52	0.3	1	0.1	97.4	6.3897	0.5743
2015	7	11	2	36	52	0.3	1	0.16	97.3	6.3897	0.8707
2015	7	11	2	46	52	0.3	1	0.16	112.4	6.3897	0.8522
2015	7	11	2	56	52	0.3	1	0.14	96.6	6.3897	0.7966
2015	7	11	3	6	52	0.3	1	0.19	91	6.3897	1.093
2015	7	11	3	16	52	0.3	1	0.19	91	6.3897	1.056
2015	7	11	3	26	52	0.3	1	0.19	93.9	6.3897	1.0745
2015	7	11	3	36	52	0.3	1	0.05	115	6.3897	0.2779

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	11	3	46	52	0.3	1	0.15	125.4	6.3897	0.704
2015	7	11	3	56	52	0.3	1	0.13	117.2	6.3897	0.6484
2015	7	11	4	6	52	0.3	1	0.15	86.2	6.3897	0.8337
2015	7	11	4	16	52	0.3	1	0.2	100.6	6.409	1.0966
2015	7	11	4	26	52	0.3	1	0.2	69.2	6.3897	1.0745
2015	7	11	4	36	52	0.3	1	0.19	82	6.3897	1.056
2015	7	11	4	46	52	0.3	1	0.14	90	6.3897	0.7781
2015	7	11	4	56	52	0.3	1	0.15	90	6.409	0.855
2015	7	11	5	6	52	0.3	1	0.2	77.4	6.3897	1.0745
2015	7	11	5	16	52	0.3	1	0.1	99.2	6.409	0.5762
2015	7	11	5	26	52	0.3	1	0.19	88.1	6.409	1.0966
2015	7	11	5	36	52	0.3	1	0.13	82.9	6.3897	0.741
2015	7	11	5	46	52	0.3	1	0.1	90	6.409	0.5762
2015	7	11	5	56	52	0.3	1	0.17	93.2	6.409	0.9851
2015	7	11	6	6	52	0.3	1	0.07	104	6.3897	0.3705
2015	7	11	6	16	52	0.3	1	0.12	88.5	6.409	0.7063
2015	7	11	6	26	52	0.3	1	0.16	88.8	6.409	0.8921
2015	7	11	6	36	52	0.3	1	0.14	90	6.3897	0.8152
2015	7	11	6	46	52	0.3	1	0.13	130	6.3897	0.5743
2015	7	11	6	56	52	0.3	1	0.12	125.9	6.3897	0.5373
2015	7	11	7	6	52	0.3	1	0.09	90	6.3897	0.4817
2015	7	11	7	16	52	0.3	1	0.12	122.8	6.409	0.5762
2015	7	11	7	26	52	0.3	1	0.17	110.6	6.409	0.8921
2015	7	11	7	36	52	0.3	1	0.19	106.2	6.409	1.0223
2015	7	11	7	46	52	0.3	1	0.14	90	6.409	0.7806
2015	7	11	7	56	52	0.3	1	0.16	73.1	6.409	0.855
2015	7	11	8	6	52	0.3	1	0.18	81.7	6.409	1.0222
2015	7	11	8	16	52	0.3	1	0.11	81.4	6.409	0.6133
2015	7	11	8	26	52	0.3	1	0.21	80.8	6.409	1.1523
2015	7	11	8	36	52	0.3	1	0.18	80.5	6.409	1.0037
2015	7	11	8	46	52	0.3	1	0.15	88.7	6.409	0.8364
2015	7	11	8	56	52	0.3	1	0.15	96.5	6.409	0.8178
2015	7	11	9	6	52	0.3	1	0.16	83.9	6.409	0.8735
2015	7	11	9	16	52	0.3	1	0.17	90	6.409	0.9851

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	11	9	26	52	0.3	1	0.11	77.7	6.409	0.5948
2015	7	11	9	36	52	0.3	1	0.18	90	6.409	1.0036
2015	7	11	9	46	52	0.3	1	0.14	83	6.409	0.762
2015	7	11	9	56	52	0.3	1	0.2	77.6	6.409	1.0966
2015	7	11	10	6	52	0.3	1	0.18	62.5	6.409	0.8921
2015	7	11	10	16	52	0.3	1	0.14	68.2	6.409	0.7434
2015	7	11	10	26	52	0.3	1	0.23	81.6	6.409	1.2638
2015	7	11	10	36	52	0.3	1	0.18	77.5	6.409	1.0036
2015	7	11	10	46	52	0.3	1	0.17	69	6.409	0.8735
2015	7	11	10	56	52	0.3	1	0.22	76.4	6.409	1.2267
2015	7	11	11	6	52	0.3	1	0.18	75.2	6.409	0.985
2015	7	11	11	16	52	0.3	1	0.15	81.3	6.409	0.8549
2015	7	11	11	26	52	0.3	1	0.18	85.8	6.409	1.0222
2015	7	11	11	36	52	0.3	1	0.25	86.2	6.409	1.3939
2015	7	11	11	46	52	0.3	1	0.15	66.2	6.409	0.7992
2015	7	11	11	56	52	0.3	1	0.18	65.8	6.409	0.9107
2015	7	11	12	6	52	0.3	1	0.19	68.2	6.409	1.0222
2015	7	11	12	16	52	0.3	1	0.16	74.5	6.3897	0.8707
2015	7	11	12	26	52	0.3	1	0.2	87.1	6.409	1.1151
2015	7	11	12	36	52	0.3	1	0.16	57.6	6.409	0.762
2015	7	11	12	46	52	0.3	1	0.12	64.8	6.409	0.6319
2015	7	11	12	56	52	0.3	1	0.21	74.9	6.3897	1.1671
2015	7	11	13	6	52	0.3	1	0.18	77.2	6.3897	0.9818
2015	7	11	13	16	52	0.3	1	0.17	78.9	6.409	0.9478
2015	7	11	13	26	52	0.3	1	0.17	60.9	6.409	0.8363
2015	7	11	13	36	52	0.3	1	0.18	63.4	6.409	0.8921
2015	7	11	13	46	52	0.3	1	0.24	76.3	6.409	1.3009
2015	7	11	13	56	52	0.3	1	0.19	74.1	6.409	1.0407
2015	7	11	14	6	52	0.3	1	0.2	63.4	6.409	1.0036
2015	7	11	14	16	52	0.3	1	0.16	69.7	6.409	0.8549
2015	7	11	14	26	52	0.3	1	0.17	86.7	6.409	0.9664
2015	7	11	14	36	52	0.3	1	0.17	60.5	6.409	0.8549
2015	7	11	14	46	52	0.3	1	0.17	84.6	6.409	0.985
2015	7	11	14	56	52	0.3	1	0.27	65.3	6.409	1.3753

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	11	15	6	52	0.3	1	0.23	77.6	6.409	1.2637
2015	7	11	15	16	52	0.3	1	0.2	80.7	6.409	1.1337
2015	7	11	15	26	52	0.3	1	0.17	78.1	6.409	0.9664
2015	7	11	15	36	52	0.3	1	0.23	49.1	6.3897	0.9633
2015	7	11	15	46	52	0.3	1	0.17	56.9	6.3897	0.7965
2015	7	11	15	56	52	0.3	1	0.22	43.8	6.409	0.8549
2015	7	11	16	6	52	0.3	1	0.21	53.1	6.3897	0.9633
2015	7	11	16	16	52	0.3	1	0.23	76.6	6.3897	1.2411
2015	7	11	16	26	52	0.3	1	0.2	62.2	6.3897	0.9818
2015	7	11	16	36	52	0.3	1	0.2	70.3	6.3897	1.0373
2015	7	11	16	46	52	0.3	1	0.19	93.9	6.3897	1.0744
2015	7	11	16	56	52	0.3	1	0.2	57.1	6.3897	0.9447
2015	7	11	17	6	52	0.3	1	0.24	46.1	6.3897	0.9818
2015	7	11	17	16	52	0.3	1	0.14	67	6.3897	0.741
2015	7	11	17	26	52	0.3	1	0.15	68.9	6.3897	0.8151
2015	7	11	17	36	52	0.3	1	0.13	82.7	6.3703	0.7201
2015	7	11	17	46	52	0.3	1	0.21	90	6.3703	1.1632
2015	7	11	17	56	52	0.3	1	0.19	61.2	6.3703	0.9417
2015	7	11	18	6	52	0.3	1	0.27	60.3	6.3703	1.3294
2015	7	11	18	16	52	0.3	1	0.21	57.8	6.3703	0.997
2015	7	11	18	26	52	0.3	1	0.14	53.7	6.3703	0.6278
2015	7	11	18	36	52	0.3	1	0.28	67.7	6.3703	1.4402
2015	7	11	18	46	52	0.3	1	0.12	83.7	6.3703	0.6647
2015	7	11	18	56	52	0.3	1	0.14	85.9	6.3703	0.7755
2015	7	11	19	6	52	0.3	1	0.22	85.8	6.3703	1.2555
2015	7	11	19	16	52	0.3	1	0.17	95.5	6.3703	0.9601
2015	7	11	19	26	52	0.3	1	0.15	119.9	6.3703	0.7386
2015	7	11	19	36	52	0.3	1	0.22	82.3	6.3703	1.2371
2015	7	11	19	46	52	0.3	1	0.16	124	6.3703	0.7386
2015	7	11	19	56	52	0.3	1	0.19	84	6.3703	1.0524
2015	7	11	20	6	52	0.3	1	0.14	101.8	6.3703	0.7939
2015	7	11	20	16	52	0.3	1	0.11	122.7	6.3703	0.517
2015	7	11	20	26	52	0.3	1	0.17	101.9	6.3703	0.9601
2015	7	11	20	36	52	0.3	1	0.23	98.4	6.3703	1.2555

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	11	20	46	52	0.3	1	0.23	124.6	6.3703	1.0709
2015	7	11	20	56	52	0.3	1	0.21	103.8	6.3703	1.1263
2015	7	11	21	6	52	0.3	1	0.21	122.7	6.3703	0.9786
2015	7	11	21	16	52	0.3	1	0.09	98.4	6.3897	0.5002
2015	7	11	21	26	52	0.3	1	0.18	101.3	6.3703	1.0155
2015	7	11	21	36	52	0.3	1	0.12	107.9	6.3703	0.6278
2015	7	11	21	46	52	0.3	1	0.24	93.9	6.3703	1.3663
2015	7	11	21	56	52	0.3	1	0.2	87.2	6.3703	1.1263
2015	7	11	22	6	52	0.3	1	0.12	79	6.3703	0.6647
2015	7	11	22	16	52	0.3	1	0.12	90	6.3703	0.6647
2015	7	11	22	26	52	0.3	1	0.16	102.9	6.3703	0.8863
2015	7	11	22	36	52	0.3	1	0.19	98	6.3703	1.0525
2015	7	11	22	46	52	0.3	1	0.11	128.7	6.3703	0.4616
2015	7	11	22	56	52	0.3	1	0.15	123.7	6.3703	0.7201
2015	7	11	23	6	52	0.3	1	0.12	98.1	6.3703	0.6463
2015	7	11	23	16	52	0.3	1	0.25	77.2	6.3703	1.3848
2015	7	11	23	26	52	0.3	1	0.07	84.8	6.3703	0.4062
2015	7	11	23	36	52	0.3	1	0.2	107	6.3703	1.0894
2015	7	11	23	46	52	0.3	1	0.14	114.8	6.3703	0.7201
2015	7	11	23	56	52	0.3	1	0.16	124.7	6.3703	0.7201
2015	7	12	0	6	52	0.3	1	0.16	105.5	6.3703	0.8678
2015	7	12	0	16	52	0.3	1	0.07	119.1	6.3703	0.3324
2015	7	12	0	26	52	0.3	1	0.09	92	6.3703	0.517
2015	7	12	0	36	52	0.3	1	0.08	96.8	6.3703	0.4616
2015	7	12	0	46	52	0.3	1	0.11	118.9	6.3703	0.5355
2015	7	12	0	56	52	0.3	1	0.08	60.3	6.3703	0.3878
2015	7	12	1	6	52	0.3	1	0.09	90	6.3703	0.4985
2015	7	12	1	16	52	0.3	1	0.2	90	6.3703	1.1263
2015	7	12	1	26	52	0.3	1	0.19	110	6.3703	1.0156
2015	7	12	1	36	52	0.3	1	0.16	108.8	6.3703	0.8678
2015	7	12	1	46	52	0.3	1	0.19	106.2	6.3703	1.0156
2015	7	12	1	56	52	0.3	1	0.16	97.3	6.3703	0.8678
2015	7	12	2	6	52	0.3	1	0.09	111.8	6.3703	0.4616
2015	7	12	2	16	52	0.3	1	0.1	90	6.3703	0.5909

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	12	2	26	52	0.3	1	0.14	113.6	6.3703	0.7201
2015	7	12	2	36	52	0.3	1	0.11	111.2	6.3703	0.5724
2015	7	12	2	46	52	0.3	1	0.03	90	6.3703	0.1847
2015	7	12	2	56	52	0.3	1	0.05	127.6	6.3703	0.24
2015	7	12	3	6	52	0.3	1	0.13	103	6.3703	0.7201
2015	7	12	3	16	52	0.3	1	0.13	82.5	6.3703	0.7017
2015	7	12	3	26	52	0.3	1	0.09	109.1	6.3703	0.4801
2015	7	12	3	36	52	0.3	1	0.13	92.8	6.3703	0.7571
2015	7	12	3	46	52	0.3	1	0.14	80.3	6.3703	0.7571
2015	7	12	3	56	52	0.3	1	0.12	104.8	6.3897	0.6299
2015	7	12	4	6	52	0.3	1	0.09	102.5	6.3703	0.4986
2015	7	12	4	16	52	0.3	1	0.1	110.1	6.3897	0.5558
2015	7	12	4	26	52	0.3	1	0.15	122.3	6.3897	0.704
2015	7	12	4	36	52	0.3	1	0.12	85.4	6.3897	0.6854
2015	7	12	4	46	52	0.3	1	0.12	90	6.3897	0.704
2015	7	12	4	56	52	0.3	1	0.14	106.3	6.3897	0.7595
2015	7	12	5	6	52	0.3	1	0.11	109.5	6.3897	0.5743
2015	7	12	5	16	52	0.3	1	0.12	98.1	6.3897	0.6484
2015	7	12	5	26	52	0.3	1	0.18	98.3	6.3897	1.0189
2015	7	12	5	36	52	0.3	1	0.17	122.1	6.3897	0.7966
2015	7	12	5	46	52	0.3	1	0.17	92.2	6.3897	0.9448
2015	7	12	5	56	52	0.3	1	0.18	82.5	6.3897	0.9819
2015	7	12	6	6	52	0.3	1	0.16	93.6	6.3897	0.8892
2015	7	12	6	16	52	0.3	1	0.24	97	6.3897	1.3524
2015	7	12	6	26	52	0.3	1	0.12	94.9	6.3897	0.6484
2015	7	12	6	36	52	0.3	1	0.07	78.7	6.3897	0.3705
2015	7	12	6	46	52	0.3	1	0.19	91	6.3897	1.093
2015	7	12	6	56	52	0.3	1	0.13	111.3	6.3897	0.6669
2015	7	12	7	6	52	0.3	1	0.1	88.2	6.3897	0.5743
2015	7	12	7	16	52	0.3	1	0.09	94.4	6.409	0.4832
2015	7	12	7	26	52	0.3	1	0.16	131.7	6.409	0.6877
2015	7	12	7	36	52	0.3	1	0.21	94.4	6.409	1.2081
2015	7	12	7	46	52	0.3	1	0.13	92.8	6.409	0.762
2015	7	12	7	56	52	0.3	1	0.13	110.2	6.409	0.7063

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	12	8	6	52	0.3	1	0.25	93.7	6.409	1.4311
2015	7	12	8	16	52	0.3	1	0.23	97.3	6.409	1.301
2015	7	12	8	26	52	0.3	1	0.12	90	6.409	0.6691
2015	7	12	8	36	52	0.3	1	0.2	92.9	6.409	1.1151
2015	7	12	8	46	52	0.3	1	0.12	91.5	6.4284	0.7085
2015	7	12	8	56	52	0.3	1	0.11	72.6	6.4284	0.5967
2015	7	12	9	6	52	0.3	1	0.15	83.7	6.4284	0.8391
2015	7	12	9	16	52	0.3	1	0.12	82.1	6.4284	0.6713
2015	7	12	9	26	52	0.3	1	0.07	92.9	6.4284	0.3729
2015	7	12	9	36	52	0.3	1	0.14	90	6.4284	0.8204
2015	7	12	9	46	52	0.3	1	0.2	91.9	6.4284	1.1188
2015	7	12	9	56	52	0.3	1	0.16	90	6.4284	0.895
2015	7	12	10	6	52	0.3	1	0.12	107	6.4284	0.6712
2015	7	12	10	16	52	0.3	1	0.16	93.5	6.4284	0.9136
2015	7	12	10	26	52	0.3	1	0.11	76	6.4284	0.5967
2015	7	12	10	36	52	0.3	1	0.12	53.7	6.4284	0.5594
2015	7	12	10	46	52	0.3	1	0.13	103.3	6.4284	0.7085
2015	7	12	10	56	52	0.3	1	0.15	83.8	6.4284	0.8577
2015	7	12	11	6	52	0.3	1	0.16	75.4	6.4284	0.8577
2015	7	12	11	16	52	0.3	1	0.17	43.4	6.4284	0.6526
2015	7	12	11	26	52	0.3	1	0.2	58.1	6.4284	0.9882
2015	7	12	11	36	52	0.3	1	0.13	60.3	6.4284	0.6526
2015	7	12	11	46	52	0.3	1	0.15	77.2	6.4284	0.8204
2015	7	12	11	56	52	0.3	1	0.22	66.9	6.4284	1.1374
2015	7	12	12	6	52	0.3	1	0.17	87.8	6.4284	0.9882
2015	7	12	12	16	52	0.3	1	0.15	83.5	6.4284	0.8204
2015	7	12	12	26	52	0.3	1	0.23	63.8	6.4284	1.1747
2015	7	12	12	36	52	0.3	1	0.2	68.6	6.4284	1.0441
2015	7	12	12	46	52	0.3	1	0.14	87.4	6.4284	0.8204
2015	7	12	12	56	52	0.3	1	0.27	61.6	6.4284	1.3425
2015	7	12	13	6	52	0.3	1	0.18	65.3	6.4284	0.9323
2015	7	12	13	16	52	0.3	1	0.22	85.8	6.4284	1.2679
2015	7	12	13	26	52	0.3	1	0.2	65.2	6.4284	1.0068
2015	7	12	13	36	52	0.3	1	0.26	56.5	6.4284	1.2119

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	12	13	46	52	0.3	1	0.21	68.2	6.4284	1.1187
2015	7	12	13	56	52	0.3	1	0.24	74.3	6.4477	1.3281
2015	7	12	14	6	52	0.3	1	0.18	73.5	6.4284	1.0068
2015	7	12	14	16	52	0.3	1	0.18	69.2	6.4284	0.9322
2015	7	12	14	26	52	0.3	1	0.18	74.9	6.4477	0.9726
2015	7	12	14	36	52	0.3	1	0.23	74.2	6.4477	1.2532
2015	7	12	14	46	52	0.3	1	0.22	79.8	6.4284	1.2492
2015	7	12	14	56	52	0.3	1	0.23	64.9	6.4284	1.1932
2015	7	12	15	6	52	0.3	1	0.21	45.6	6.4284	0.8576
2015	7	12	15	16	52	0.3	1	0.19	61.2	6.4477	0.9539
2015	7	12	15	26	52	0.3	1	0.3	51.7	6.4284	1.3237
2015	7	12	15	36	52	0.3	1	0.21	45	6.4477	0.8604
2015	7	12	15	46	52	0.3	1	0.12	52.5	6.4477	0.5611
2015	7	12	15	56	52	0.3	1	0.16	54.1	6.4477	0.7482
2015	7	12	16	6	52	0.3	1	0.18	57.4	6.4477	0.8791
2015	7	12	16	16	52	0.3	1	0.21	81	6.4477	1.1784
2015	7	12	16	26	52	0.3	1	0.18	65.7	6.4477	0.9539
2015	7	12	16	36	52	0.3	1	0.17	37.8	6.4477	0.5798
2015	7	12	16	46	52	0.3	1	0.16	49.3	6.4477	0.6734
2015	7	12	16	56	52	0.3	1	0.22	68.4	6.4477	1.1784
2015	7	12	17	6	52	0.3	1	0.22	72.4	6.4477	1.1784
2015	7	12	17	16	52	0.3	1	0.2	69.2	6.4477	1.0849
2015	7	12	17	26	52	0.3	1	0.17	90	6.4477	0.9539
2015	7	12	17	36	52	0.3	1	0.17	85.7	6.4477	0.9913
2015	7	12	17	46	52	0.3	1	0.17	70.9	6.4284	0.9136
2015	7	12	17	56	52	0.3	1	0.13	82.5	6.4284	0.7085
2015	7	12	18	6	52	0.3	1	0.21	90.9	6.4284	1.1932
2015	7	12	18	16	52	0.3	1	0.18	86.8	6.4284	1.0068
2015	7	12	18	26	52	0.3	1	0.2	93.8	6.4284	1.1187
2015	7	12	18	36	52	0.3	1	0.18	68.6	6.4284	0.9509
2015	7	12	18	46	52	0.3	1	0.19	88	6.4284	1.0627
2015	7	12	18	56	52	0.3	1	0.17	100.9	6.4284	0.9695
2015	7	12	19	6	52	0.3	1	0.14	106.3	6.4284	0.7644
2015	7	12	19	16	52	0.3	1	0.11	91.8	6.4284	0.5966

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	12	19	26	52	0.3	1	0.23	112.1	6.4284	1.1932
2015	7	12	19	36	52	0.3	1	0.19	142.9	6.4284	0.6339
2015	7	12	19	46	52	0.3	1	0.18	110.1	6.4284	0.9695
2015	7	12	19	56	52	0.3	1	0.11	93.4	6.4284	0.6339
2015	7	12	20	6	52	0.3	1	0.18	112	6.4284	0.9695
2015	7	12	20	16	52	0.3	1	0.16	99.3	6.4284	0.9136
2015	7	12	20	26	52	0.3	1	0.19	79.1	6.4284	1.0627
2015	7	12	20	36	52	0.3	1	0.23	92.4	6.4477	1.328
2015	7	12	20	46	52	0.3	1	0.14	117.1	6.4284	0.7271
2015	7	12	20	56	52	0.3	1	0.24	104.4	6.4477	1.3093
2015	7	12	21	6	52	0.3	1	0.16	92.4	6.4284	0.8949
2015	7	12	21	16	52	0.3	1	0.19	95.9	6.4477	1.0849
2015	7	12	21	26	52	0.3	1	0.14	114.8	6.4477	0.7295
2015	7	12	21	36	52	0.3	1	0.15	91.2	6.4477	0.8791
2015	7	12	21	46	52	0.3	1	0.11	109.5	6.4477	0.5798
2015	7	12	21	56	52	0.3	1	0.14	88.7	6.4477	0.823
2015	7	12	22	6	52	0.3	1	0.16	99.7	6.4284	0.8763
2015	7	12	22	16	52	0.3	1	0.18	95.3	6.4284	1.0068
2015	7	12	22	26	52	0.3	1	0.21	97.1	6.4284	1.1933
2015	7	12	22	36	52	0.3	1	0.23	100	6.4284	1.2678
2015	7	12	22	46	52	0.3	1	0.11	128.7	6.4284	0.4661
2015	7	12	22	56	52	0.3	1	0.18	101.7	6.4284	0.9882
2015	7	12	23	6	52	0.3	1	0.17	105.6	6.4284	0.9322
2015	7	12	23	16	52	0.3	1	0.14	87.3	6.4284	0.8017
2015	7	12	23	26	52	0.3	1	0.14	122.6	6.4284	0.6712
2015	7	12	23	36	52	0.3	1	0.1	102.7	6.4284	0.578
2015	7	12	23	46	52	0.3	1	0.12	113.2	6.4284	0.6526
2015	7	12	23	56	52	0.3	1	0.14	90	6.4284	0.8204
2015	7	13	0	6	52	0.3	1	0.17	103.5	6.4284	0.9322
2015	7	13	0	16	52	0.3	1	0.19	81.2	6.4284	1.0814
2015	7	13	0	26	52	0.3	1	0.15	104.9	6.4284	0.839
2015	7	13	0	36	52	0.3	1	0.23	103.4	6.4284	1.2492
2015	7	13	0	46	52	0.3	1	0.13	107.1	6.4284	0.7272
2015	7	13	0	56	52	0.3	1	0.22	112	6.4284	1.156

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	13	1	6	52	0.3	1	0.17	119.1	6.4284	0.839
2015	7	13	1	16	52	0.3	1	0.15	125.8	6.4284	0.6712
2015	7	13	1	26	52	0.3	1	0.11	83.1	6.4284	0.6153
2015	7	13	1	36	52	0.3	1	0.1	123.2	6.4284	0.4848
2015	7	13	1	46	52	0.3	1	0.13	108.9	6.4284	0.7085
2015	7	13	1	56	52	0.3	1	0.11	109.5	6.4284	0.578
2015	7	13	2	6	52	0.3	1	0.13	121.7	6.409	0.6319
2015	7	13	2	16	52	0.3	1	0.12	85.1	6.409	0.6505
2015	7	13	2	26	52	0.3	1	0.14	120.1	6.409	0.7062
2015	7	13	2	36	52	0.3	1	0.15	118.3	6.409	0.7248
2015	7	13	2	46	52	0.3	1	0.11	102.3	6.409	0.5947
2015	7	13	2	56	52	0.3	1	0.13	114	6.409	0.6691
2015	7	13	3	6	52	0.3	1	0.14	90	6.409	0.8178
2015	7	13	3	16	52	0.3	1	0.04	135	6.409	0.1673
2015	7	13	3	26	52	0.3	1	0.16	108.8	6.409	0.8735
2015	7	13	3	36	52	0.3	1	0.09	111.8	6.409	0.4646
2015	7	13	3	46	52	0.3	1	0.13	94.3	6.409	0.7434
2015	7	13	3	56	52	0.3	1	0.12	117.3	6.409	0.6133
2015	7	13	4	6	52	0.3	1	0.11	107.4	6.409	0.5947
2015	7	13	4	16	52	0.3	1	0.15	135	6.409	0.6133
2015	7	13	4	26	52	0.3	1	0.11	95.4	6.409	0.5947
2015	7	13	4	36	52	0.3	1	0.13	85.7	6.409	0.7434
2015	7	13	4	46	52	0.3	1	0.1	114	6.409	0.5018
2015	7	13	4	56	52	0.3	1	0.12	85.4	6.409	0.6877
2015	7	13	5	6	52	0.3	1	0.17	121	6.409	0.8364
2015	7	13	5	16	52	0.3	1	0.13	84.1	6.3897	0.7225
2015	7	13	5	26	52	0.3	1	0.21	105.6	6.3897	1.13
2015	7	13	5	36	52	0.3	1	0.15	101.1	6.3897	0.8522
2015	7	13	5	46	52	0.3	1	0.15	82.2	6.3897	0.8151
2015	7	13	5	56	52	0.3	1	0.12	115.2	6.3897	0.6299
2015	7	13	6	6	52	0.3	1	0.16	127.3	6.3897	0.704
2015	7	13	6	16	52	0.3	1	0.13	99	6.3897	0.704
2015	7	13	6	26	52	0.3	1	0.14	100.5	6.3897	0.7966
2015	7	13	6	36	52	0.3	1	0.17	124	6.3897	0.7966

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	13	6	46	52	0.3	1	0.13	90	6.3897	0.7225
2015	7	13	6	56	52	0.3	1	0.15	85	6.3897	0.8522
2015	7	13	7	6	52	0.3	1	0.09	90	6.3897	0.4817
2015	7	13	7	16	52	0.3	1	0.08	85.2	6.3897	0.4446
2015	7	13	7	26	52	0.3	1	0.19	73.8	6.3897	1.0189
2015	7	13	7	36	52	0.3	1	0.14	79.2	6.3897	0.7781
2015	7	13	7	46	52	0.3	1	0.19	94.8	6.3897	1.093
2015	7	13	7	56	52	0.3	1	0.19	112.5	6.3897	0.9818
2015	7	13	8	6	52	0.3	1	0.11	83.1	6.409	0.6133
2015	7	13	8	16	52	0.3	1	0.17	75.4	6.409	0.9293
2015	7	13	8	26	52	0.3	1	0.12	82.1	6.3897	0.6669
2015	7	13	8	36	52	0.3	1	0.09	98.4	6.3897	0.5002
2015	7	13	8	46	52	0.3	1	0.11	190	6.409	-0.1115
2015	7	13	8	56	52	0.3	1	0.07	104	6.409	0.3717
2015	7	13	9	6	52	0.3	1	0.1	118.3	6.409	0.4832
2015	7	13	9	16	52	0.3	1	0.13	81.5	6.409	0.7434
2015	7	13	9	26	52	0.3	1	0.13	114	6.409	0.6691
2015	7	13	9	36	52	0.3	1	0.09	81.3	6.409	0.4832
2015	7	13	9	46	52	0.3	1	0.15	65.1	6.409	0.762
2015	7	13	9	56	52	0.3	1	0.13	79.6	6.409	0.7062
2015	7	13	10	6	52	0.3	1	0.17	105.9	6.409	0.9107
2015	7	13	10	16	52	0.3	1	0.12	90	6.409	0.6691
2015	7	13	10	26	52	0.3	1	0.16	64	6.409	0.7992
2015	7	13	10	36	52	0.3	1	0.12	64.8	6.4284	0.6339
2015	7	13	10	46	52	0.3	1	0.18	79.3	6.4284	0.9882
2015	7	13	10	56	52	0.3	1	0.19	82.9	6.409	1.0408
2015	7	13	11	6	52	0.3	1	0.17	99.1	6.4284	0.9323
2015	7	13	11	16	52	0.3	1	0.14	66.4	6.409	0.7248
2015	7	13	11	26	52	0.3	1	0.13	66	6.409	0.669
2015	7	13	11	36	52	0.3	1	0.18	77.7	6.409	1.0222
2015	7	13	11	46	52	0.3	1	0.13	44	6.4284	0.5034
2015	7	13	11	56	52	0.3	1	0.18	64.4	6.409	0.9292
2015	7	13	12	6	52	0.3	1	0.22	76	6.409	1.1894
2015	7	13	12	16	52	0.3	1	0.19	81.2	6.409	1.0779

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	13	12	26	52	0.3	1	0.2	56.6	6.409	0.9292
2015	7	13	12	36	52	0.3	1	0.14	74.6	6.409	0.7434
2015	7	13	12	46	52	0.3	1	0.14	68.7	6.409	0.762
2015	7	13	12	56	52	0.3	1	0.14	61.6	6.4284	0.6899
2015	7	13	13	6	52	0.3	1	0.23	52	6.4284	1.0255
2015	7	13	13	16	52	0.3	1	0.19	85	6.4284	1.0627
2015	7	13	13	26	52	0.3	1	0.15	69.6	6.4284	0.8017
2015	7	13	13	36	52	0.3	1	0.16	59.2	6.4284	0.7831
2015	7	13	13	46	52	0.3	1	0.16	51	6.4284	0.6898
2015	7	13	13	56	52	0.3	1	0.16	59.7	6.4284	0.7644
2015	7	13	14	6	52	0.3	1	0.25	63.1	6.4284	1.2864
2015	7	13	14	16	52	0.3	1	0.2	77.6	6.4284	1.1
2015	7	13	14	26	52	0.3	1	0.25	64.8	6.4284	1.3051
2015	7	13	14	36	52	0.3	1	0.16	70.1	6.4284	0.8763
2015	7	13	14	46	52	0.3	1	0.16	50.8	6.4284	0.7085
2015	7	13	14	56	52	0.3	1	0.2	51.6	6.4284	0.8949
2015	7	13	15	6	52	0.3	1	0.25	64.8	6.4284	1.2678
2015	7	13	15	16	52	0.3	1	0.22	64.6	6.4284	1.1373
2015	7	13	15	26	52	0.3	1	0.24	62.4	6.4284	1.2118
2015	7	13	15	36	52	0.3	1	0.24	75.6	6.4284	1.3051
2015	7	13	15	46	52	0.3	1	0.21	60.6	6.4477	1.0287
2015	7	13	15	56	52	0.3	1	0.21	52.8	6.4477	0.9352
2015	7	13	16	6	52	0.3	1	0.21	54.6	6.4477	0.9726
2015	7	13	16	16	52	0.3	1	0.12	61.3	6.4477	0.5798
2015	7	13	16	26	52	0.3	1	0.2	69.2	6.4284	1.0813
2015	7	13	16	36	52	0.3	1	0.18	65.3	6.4477	0.9352
2015	7	13	16	46	52	0.3	1	0.14	69.9	6.4477	0.7669
2015	7	13	16	56	52	0.3	1	0.19	58.2	6.4477	0.9352
2015	7	13	17	6	52	0.3	1	0.22	76.2	6.4477	1.2158
2015	7	13	17	16	52	0.3	1	0.17	86.8	6.4284	0.9881
2015	7	13	17	26	52	0.3	1	0.11	81.4	6.4477	0.6172
2015	7	13	17	36	52	0.3	1	0.23	108.9	6.4477	1.2532
2015	7	13	17	46	52	0.3	1	0.12	91.5	6.4284	0.6898
2015	7	13	17	56	52	0.3	1	0.16	92.4	6.4284	0.8949

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	13	18	6	52	0.3	1	0.14	91.4	6.4284	0.783
2015	7	13	18	16	52	0.3	1	0.11	78	6.4284	0.6152
2015	7	13	18	26	52	0.3	1	0.12	102.2	6.4284	0.6898
2015	7	13	18	36	52	0.3	1	0.15	91.2	6.4284	0.8763
2015	7	13	18	46	52	0.3	1	0.13	94.4	6.4284	0.7271
2015	7	13	18	56	52	0.3	1	0.18	102.8	6.4284	0.9881
2015	7	13	19	6	52	0.3	1	0.18	115.2	6.4284	0.9508
2015	7	13	19	16	52	0.3	1	0.18	103	6.4284	0.9695
2015	7	13	19	26	52	0.3	1	0.22	77.2	6.4284	1.2305
2015	7	13	19	36	52	0.3	1	0.16	102	6.4284	0.8763
2015	7	13	19	46	52	0.3	1	0.21	82	6.4284	1.1932
2015	7	13	19	56	52	0.3	1	0.17	96.6	6.4284	0.9695
2015	7	13	20	6	52	0.3	1	0.19	91.9	6.4284	1.1
2015	7	13	20	16	52	0.3	1	0.23	102.4	6.4284	1.2678
2015	7	13	20	26	52	0.3	1	0.19	90	6.4477	1.0661
2015	7	13	20	36	52	0.3	1	0.2	72.1	6.4477	1.1035
2015	7	13	20	46	52	0.3	1	0.12	87	6.4477	0.7108
2015	7	13	20	56	52	0.3	1	0.14	106.3	6.4477	0.7669
2015	7	13	21	6	52	0.3	1	0.16	109.2	6.4477	0.8604
2015	7	13	21	16	52	0.3	1	0.15	122.3	6.4284	0.7085
2015	7	13	21	26	52	0.3	1	0.21	105.1	6.4284	1.1746
2015	7	13	21	36	52	0.3	1	0.22	117.3	6.4477	1.1223
2015	7	13	21	46	52	0.3	1	0.17	104.9	6.4477	0.9165
2015	7	13	21	56	52	0.3	1	0.24	104.4	6.4477	1.3093
2015	7	13	22	6	52	0.3	1	0.2	107	6.4477	1.1036
2015	7	13	22	16	52	0.3	1	0.11	72.6	6.4477	0.5985
2015	7	13	22	26	52	0.3	1	0.17	84.4	6.4477	0.9539
2015	7	13	22	36	52	0.3	1	0.09	138	6.4477	0.3367
2015	7	13	22	46	52	0.3	1	0.18	88.9	6.4477	1.01
2015	7	13	22	56	52	0.3	1	0.15	97.6	6.4477	0.8417
2015	7	13	23	6	52	0.3	1	0.11	88.4	6.4477	0.6547
2015	7	13	23	16	52	0.3	1	0.14	123.7	6.4477	0.6734
2015	7	13	23	26	52	0.3	1	0.2	95.5	6.4477	1.1597
2015	7	13	23	36	52	0.3	1	0.17	93.4	6.4477	0.9539

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	13	23	46	52	0.3	1	0.14	104	6.4477	0.7482
2015	7	13	23	56	52	0.3	1	0.22	103.8	6.4477	1.2158
2015	7	14	0	6	52	0.3	1	0.22	94.3	6.4477	1.2345
2015	7	14	0	16	52	0.3	1	0.18	103.5	6.4477	1.0101
2015	7	14	0	26	52	0.3	1	0.14	69	6.4477	0.7295
2015	7	14	0	36	52	0.3	1	0.14	105.4	6.4477	0.7482
2015	7	14	0	46	52	0.3	1	0.14	122.2	6.4477	0.6547
2015	7	14	0	56	52	0.3	1	0.18	117.5	6.4477	0.9353
2015	7	14	1	6	52	0.3	1	0.17	84.6	6.4477	0.9914
2015	7	14	1	16	52	0.3	1	0.17	130.2	6.4284	0.7271
2015	7	14	1	26	52	0.3	1	0.14	95.3	6.4477	0.8043
2015	7	14	1	36	52	0.3	1	0.18	112.8	6.4284	0.9322
2015	7	14	1	46	52	0.3	1	0.18	102.5	6.4284	1.0068
2015	7	14	1	56	52	0.3	1	0.16	134.1	6.4284	0.6339
2015	7	14	2	6	52	0.3	1	0.17	119.1	6.4284	0.839
2015	7	14	2	16	52	0.3	1	0.18	112.4	6.4284	0.9509
2015	7	14	2	26	52	0.3	1	0.16	133.4	6.4284	0.6712
2015	7	14	2	36	52	0.3	1	0.16	109.9	6.4284	0.8763
2015	7	14	2	46	52	0.3	1	0.1	107.8	6.4284	0.5221
2015	7	14	2	56	52	0.3	1	0.13	107.1	6.4284	0.7272
2015	7	14	3	6	52	0.3	1	0.09	104.5	6.4284	0.5034
2015	7	14	3	16	52	0.3	1	0.17	114.5	6.4284	0.8577
2015	7	14	3	26	52	0.3	1	0.13	90	6.4284	0.7272
2015	7	14	3	36	52	0.3	1	0.14	114.1	6.4284	0.7085
2015	7	14	3	46	52	0.3	1	0.13	91.5	6.4284	0.7272
2015	7	14	3	56	52	0.3	1	0.15	135	6.4284	0.6153
2015	7	14	4	6	52	0.3	1	0.2	117.4	6.4284	1.0068
2015	7	14	4	16	52	0.3	1	0.15	69.6	6.4284	0.8017
2015	7	14	4	26	52	0.3	1	0.15	136.7	6.4284	0.5967
2015	7	14	4	36	52	0.3	1	0.17	107	6.4284	0.9136
2015	7	14	4	46	52	0.3	1	0.13	138.9	6.4284	0.5034
2015	7	14	4	56	52	0.3	1	0.15	125.4	6.4284	0.7085
2015	7	14	5	6	52	0.3	1	0.12	93.2	6.409	0.6691
2015	7	14	5	16	52	0.3	1	0.2	121.9	6.409	0.985

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	14	5	26	52	0.3	1	0.14	109.7	6.409	0.7248
2015	7	14	5	36	52	0.3	1	0.18	128.5	6.409	0.8177
2015	7	14	5	46	52	0.3	1	0.11	109.5	6.409	0.5761
2015	7	14	5	56	52	0.3	1	0.19	72.8	6.409	1.0222
2015	7	14	6	6	52	0.3	1	0.17	114.5	6.409	0.8549
2015	7	14	6	16	52	0.3	1	0.18	106.1	6.409	0.9664
2015	7	14	6	26	52	0.3	1	0.1	118.3	6.409	0.4832
2015	7	14	6	36	52	0.3	1	0.08	133.3	6.3897	0.3149
2015	7	14	6	46	52	0.3	1	0.14	114.1	6.409	0.7062
2015	7	14	6	56	52	0.3	1	0.17	115.1	6.409	0.8735
2015	7	14	7	6	52	0.3	1	0.17	102.2	6.3897	0.9448
2015	7	14	7	16	52	0.3	1	0.11	149	6.3897	0.3335
2015	7	14	7	26	52	0.3	1	0.1	90	6.3897	0.5928
2015	7	14	7	36	52	0.3	1	0.12	75.2	6.3897	0.6298
2015	7	14	7	46	52	0.3	1	0.21	65.4	6.3897	1.093
2015	7	14	7	56	52	0.3	1	0.17	92.2	6.3897	0.9818
2015	7	14	8	6	52	0.3	1	0.21	200.4	6.3897	-0.4075
2015	7	14	8	16	52	0.3	1	0.27	187.7	6.3897	-0.2038
2015	7	14	8	26	52	0.3	1	0.13	135	6.3897	0.5372
2015	7	14	8	36	52	0.3	1	0.07	90	6.3897	0.4075
2015	7	14	8	46	52	0.3	1	0.15	108.8	6.3703	0.8124
2015	7	14	8	56	52	0.3	1	0.22	69.6	6.3703	1.1448
2015	7	14	9	6	52	0.3	1	0.16	97.3	6.3703	0.8678
2015	7	14	9	16	52	0.3	1	0.14	130.3	6.3703	0.6093
2015	7	14	9	26	52	0.3	1	0.07	90	6.3703	0.4062
2015	7	14	9	36	52	0.3	1	0.11	81.6	6.3703	0.6278
2015	7	14	9	46	52	0.3	1	0.14	99.7	6.3703	0.757
2015	7	14	9	56	52	0.3	1	0.1	114	6.3509	0.4969
2015	7	14	10	6	52	0.3	1	0.1	114.9	6.3703	0.517
2015	7	14	10	16	52	0.3	1	0.18	54	6.3509	0.8098
2015	7	14	10	26	52	0.3	1	0.16	55.7	6.3509	0.7546
2015	7	14	10	36	52	0.3	1	0.19	62.1	6.3509	0.9386
2015	7	14	10	46	52	0.3	1	0.05	203.2	6.3509	-0.1104
2015	7	14	10	56	52	0.3	1	0.21	84.6	6.3316	1.1556

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	14	11	6	52	0.3	1	0.18	125.4	6.3316	0.8255
2015	7	14	11	16	52	0.3	1	0.13	50.2	6.3122	0.5485
2015	7	14	11	26	52	0.3	1	0.19	75.7	6.3122	1.0056
2015	7	14	11	36	52	0.3	1	0.04	122.5	6.2929	0.2005
2015	7	14	11	46	52	0.3	1	0.09	79.5	6.2735	0.4904
2015	7	14	11	56	52	0.3	1	0.11	76	6.2542	0.5793
2015	7	14	12	6	52	0.3	1	0.17	59	6.2542	0.8146
2015	7	14	12	16	52	0.3	1	0.16	65.6	6.2542	0.7965
2015	7	14	12	26	52	0.3	1	0.14	74.6	6.2348	0.7217
2015	7	14	12	36	52	0.3	1	0.18	71.9	6.2348	0.9382
2015	7	14	12	46	52	0.3	1	0.17	86.6	6.2348	0.9202
2015	7	14	12	56	52	0.3	1	0.2	63	6.2348	0.9923
2015	7	14	13	6	52	0.3	1	0.13	88.5	6.2154	0.7013
2015	7	14	13	16	52	0.3	1	0.13	45	6.2348	0.5052
2015	7	14	13	26	52	0.3	1	0.21	64.2	6.2348	1.0464
2015	7	14	13	36	52	0.3	1	0.16	75.4	6.2154	0.8272
2015	7	14	13	46	52	0.3	1	0.19	47.1	6.2154	0.7732
2015	7	14	13	56	52	0.3	1	0.14	71.1	6.2154	0.7373
2015	7	14	14	6	52	0.3	1	0.11	90	6.2154	0.6114
2015	7	14	14	16	52	0.3	1	0.08	45	6.2154	0.3237
2015	7	14	14	26	52	0.3	1	0.14	74.6	6.2154	0.7193
2015	7	14	14	36	52	0.3	1	0.17	58.1	6.2154	0.8092
2015	7	14	14	46	52	0.3	1	0.12	62	6.2154	0.5754
2015	7	14	14	56	52	0.3	1	0.16	81.5	6.2154	0.8451
2015	7	14	15	6	52	0.3	1	0.12	55.9	6.2154	0.5574
2015	7	14	15	16	52	0.3	1	0.16	69.7	6.2154	0.8271
2015	7	14	15	26	52	0.3	1	0.08	67.8	6.2154	0.3956
2015	7	14	15	36	52	0.3	1	0.19	63.9	6.2154	0.953
2015	7	14	15	46	52	0.3	1	0.17	45	6.2154	0.6473
2015	7	14	15	56	52	0.3	1	0.16	81.7	6.2154	0.8631
2015	7	14	16	6	52	0.3	1	0.2	49.7	6.2154	0.8271
2015	7	14	16	16	52	0.3	1	0.24	63.1	6.1961	1.1649
2015	7	14	16	26	52	0.3	1	0.18	49.5	6.1961	0.7348
2015	7	14	16	36	52	0.3	1	0.16	54.7	6.1961	0.7348

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	14	16	46	52	0.3	1	0.22	61.9	6.1961	1.0394
2015	7	14	16	56	52	0.3	1	0.12	69.6	6.1961	0.6272
2015	7	14	17	6	52	0.3	1	0.1	48.8	6.1961	0.4301
2015	7	14	17	16	52	0.3	1	0.15	65.1	6.1961	0.7348
2015	7	14	17	26	52	0.3	1	0.19	99	6.1767	1.0181
2015	7	14	17	36	52	0.3	1	0.14	67.2	6.1961	0.681
2015	7	14	17	46	52	0.3	1	0.19	67.1	6.1767	0.9288
2015	7	14	17	56	52	0.3	1	0.19	49.9	6.1767	0.7859
2015	7	14	18	6	52	0.3	1	0.18	57.8	6.1767	0.8216
2015	7	14	18	16	52	0.3	1	0.16	54.7	6.1767	0.7323
2015	7	14	18	26	52	0.3	1	0.11	45	6.1767	0.4287
2015	7	14	18	36	52	0.3	1	0.16	35.3	6.1767	0.518
2015	7	14	18	46	52	0.3	1	0.19	48.4	6.1767	0.7859
2015	7	14	18	56	52	0.3	1	0.18	54	6.1767	0.7859
2015	7	14	19	6	52	0.3	1	0.17	56.9	6.1574	0.7654
2015	7	14	19	16	52	0.3	1	0.1	64.3	6.1574	0.4806
2015	7	14	19	26	52	0.3	1	0.07	95.4	6.1574	0.3738
2015	7	14	19	36	52	0.3	1	0.1	68.6	6.1574	0.4984
2015	7	14	19	46	52	0.3	1	0.15	112.7	6.1574	0.7654
2015	7	14	19	56	52	0.3	1	0.13	80.1	6.1574	0.712
2015	7	14	20	6	52	0.3	1	0.09	100.5	6.1574	0.4806
2015	7	14	20	16	52	0.3	1	0.18	80.4	6.1574	0.9435
2015	7	14	20	26	52	0.3	1	0.19	84.1	6.138	1.029
2015	7	14	20	36	52	0.3	1	0.07	113.2	6.138	0.3726
2015	7	14	20	46	52	0.3	1	0.12	77.1	6.1574	0.623
2015	7	14	20	56	52	0.3	1	0.16	97.1	6.138	0.8516
2015	7	14	21	6	52	0.3	1	0.06	80	6.1574	0.3026
2015	7	14	21	16	52	0.3	1	0.07	130.9	6.1574	0.267
2015	7	14	21	26	52	0.3	1	0.13	73.9	6.1574	0.6764
2015	7	14	21	36	52	0.3	1	0.11	90	6.138	0.6209
2015	7	14	21	46	52	0.3	1	0.14	120.3	6.138	0.6387
2015	7	14	21	56	52	0.3	1	0.19	107.2	6.138	0.9758
2015	7	14	22	6	52	0.3	1	0.18	88.9	6.138	0.958
2015	7	14	22	16	52	0.3	1	0.11	78	6.138	0.5855

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	14	22	26	52	0.3	1	0.1	105.4	6.138	0.5145
2015	7	14	22	36	52	0.3	1	0.1	118.3	6.138	0.4613
2015	7	14	22	46	52	0.3	1	0.1	102.7	6.138	0.55
2015	7	14	22	56	52	0.3	1	0.12	122	6.138	0.5677
2015	7	14	23	6	52	0.3	1	0.16	104.3	6.138	0.8338
2015	7	14	23	16	52	0.3	1	0.13	90	6.1187	0.7249
2015	7	14	23	26	52	0.3	1	0.1	90	6.1187	0.5128
2015	7	14	23	36	52	0.3	1	0.13	119.7	6.1187	0.6188
2015	7	14	23	46	52	0.3	1	0.1	67.8	6.0993	0.4758
2015	7	14	23	56	52	0.3	1	0.1	64.3	6.0993	0.4758
2015	7	15	0	6	52	0.3	1	0.08	119.7	6.1187	0.3713
2015	7	15	0	16	52	0.3	1	0.16	97.3	6.0993	0.8282
2015	7	15	0	26	52	0.3	1	0.09	83.7	6.0993	0.4758
2015	7	15	0	36	52	0.3	1	0.1	67.8	6.08	0.4742
2015	7	15	0	46	52	0.3	1	0.13	96	6.0606	0.665
2015	7	15	0	56	52	0.3	1	0.15	91.2	6.0412	0.8023
2015	7	15	1	6	52	0.3	1	0.15	102.3	6.0412	0.8023
2015	7	15	1	16	52	0.3	1	0.13	120.5	6.0412	0.593
2015	7	15	1	26	52	0.3	1	0.09	119.5	6.0412	0.4011
2015	7	15	1	36	52	0.3	1	0.04	99.5	6.0412	0.2093
2015	7	15	1	46	52	0.3	1	0.1	88.1	6.0412	0.5232
2015	7	15	1	56	52	0.3	1	0.11	81.1	6.0219	0.5562
2015	7	15	2	6	52	0.3	1	0.08	87.5	6.0219	0.3998
2015	7	15	2	16	52	0.3	1	0.15	96.3	6.0219	0.7822
2015	7	15	2	26	52	0.3	1	0.08	90	6.0219	0.4172
2015	7	15	2	36	52	0.3	1	0.11	131.3	6.0219	0.4345
2015	7	15	2	46	52	0.3	1	0.06	110.6	6.0219	0.2781
2015	7	15	2	56	52	0.3	1	0.11	71.6	6.0025	0.5716
2015	7	15	3	6	52	0.3	1	0.15	91.2	6.0025	0.8141
2015	7	15	3	16	52	0.3	1	0.1	104.9	6.0025	0.5196
2015	7	15	3	26	52	0.3	1	0.09	98.7	6.0025	0.4504
2015	7	15	3	36	52	0.3	1	0.09	114.8	6.0025	0.4504
2015	7	15	3	46	52	0.3	1	0.08	78.2	6.0025	0.4157
2015	7	15	3	56	52	0.3	1	0.12	87	6.0025	0.6582

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	15	4	6	52	0.3	1	0.09	85.8	6.0025	0.4677
2015	7	15	4	16	52	0.3	1	0.19	97.1	5.9832	0.9667
2015	7	15	4	26	52	0.3	1	0.13	92.9	5.9832	0.6732
2015	7	15	4	36	52	0.3	1	0.12	90	6.0025	0.6582
2015	7	15	4	46	52	0.3	1	0.08	117.6	6.0025	0.3638
2015	7	15	4	56	52	0.3	1	0.05	72.6	6.0025	0.2772
2015	7	15	5	6	52	0.3	1	0.06	180	6.0025	0
2015	7	15	5	16	52	0.3	1	0.19	119.2	6.0025	0.8661
2015	7	15	5	26	52	0.3	1	0.13	107.5	6.0025	0.6582
2015	7	15	5	36	52	0.3	1	0.03	130.6	6.0025	0.1213
2015	7	15	5	46	52	0.3	1	0.17	101.9	6.0025	0.9007
2015	7	15	5	56	52	0.3	1	0.11	100	6.0219	0.591
2015	7	15	6	6	52	0.3	1	0.05	111.8	6.0219	0.2607
2015	7	15	6	16	52	0.3	1	0.12	139.6	6.0606	0.4026
2015	7	15	6	26	52	0.3	1	0.13	126.6	6.0606	0.5426
2015	7	15	6	36	52	0.3	1	0.08	64.5	6.08	0.3688
2015	7	15	6	46	52	0.3	1	0.12	122	6.08	0.562
2015	7	15	6	56	52	0.3	1	0.18	110.4	6.08	0.8957
2015	7	15	7	6	52	0.3	1	0.1	67.8	6.08	0.4742
2015	7	15	7	16	52	0.3	1	0.11	86.4	6.0993	0.5639
2015	7	15	7	26	52	0.3	1	0.12	131.8	6.0993	0.4934
2015	7	15	7	36	52	0.3	1	0.16	75.4	6.0993	0.8106
2015	7	15	7	46	52	0.3	1	0.03	90	6.1187	0.1768
2015	7	15	7	56	52	0.3	1	0.16	86.6	6.1187	0.8841
2015	7	15	8	6	52	0.3	1	0.19	64.3	6.138	0.9226
2015	7	15	8	16	52	0.3	1	0.13	174	6.1187	0.0707
2015	7	15	8	26	52	0.3	1	0.09	155.2	6.138	0.2129
2015	7	15	8	36	52	0.3	1	0.12	98.1	6.138	0.621
2015	7	15	8	46	52	0.3	1	0.07	90	6.138	0.3903
2015	7	15	8	56	52	0.3	1	0.1	115.7	6.1767	0.4823
2015	7	15	9	6	52	0.3	1	0.08	106.3	6.1767	0.4287
2015	7	15	9	16	52	0.3	1	0.11	88.4	6.1767	0.6252
2015	7	15	9	26	52	0.3	1	0.16	116.6	6.1767	0.786
2015	7	15	9	36	52	0.3	1	0.19	73.8	6.1767	0.9825

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	15	9	46	52	0.3	1	0.17	84.5	6.1767	0.9289
2015	7	15	9	56	52	0.3	1	0.12	80.3	6.1767	0.6252
2015	7	15	10	6	52	0.3	1	0.1	90	6.1767	0.518
2015	7	15	10	16	52	0.3	1	0.07	106.7	6.1767	0.3573
2015	7	15	10	26	52	0.3	1	0.13	84.1	6.1767	0.6966
2015	7	15	10	36	52	0.3	1	0.11	78.4	6.1767	0.6073
2015	7	15	10	46	52	0.3	1	0.1	64.3	6.1767	0.4823
2015	7	15	10	56	52	0.3	1	0.11	81.6	6.1767	0.6073
2015	7	15	11	6	52	0.3	1	0.06	74.5	6.1961	0.3226
2015	7	15	11	16	52	0.3	1	0.13	84	6.1961	0.6811
2015	7	15	11	26	52	0.3	1	0.11	107.4	6.1961	0.5735
2015	7	15	11	36	52	0.3	1	0.16	86.5	6.1961	0.8782
2015	7	15	11	46	52	0.3	1	0.13	90	6.1961	0.699
2015	7	15	11	56	52	0.3	1	0.17	125.5	6.1961	0.7528
2015	7	15	12	6	52	0.3	1	0.08	90	6.1961	0.4301
2015	7	15	12	16	52	0.3	1	0.1	61.7	6.1961	0.466
2015	7	15	12	26	52	0.3	1	0.12	85.1	6.1961	0.6273
2015	7	15	12	36	52	0.3	1	0.13	90	6.1961	0.699
2015	7	15	12	46	52	0.3	1	0.21	79	6.2154	1.1149
2015	7	15	12	56	52	0.3	1	0.18	76	6.2154	0.9351
2015	7	15	13	6	52	0.3	1	0.18	90	6.2154	0.9711
2015	7	15	13	16	52	0.3	1	0.19	53.5	6.2348	0.83
2015	7	15	13	26	52	0.3	1	0.11	47.4	6.2348	0.4511
2015	7	15	13	36	52	0.3	1	0.12	107	6.2348	0.6495
2015	7	15	13	46	52	0.3	1	0.16	67.1	6.2542	0.8146
2015	7	15	13	56	52	0.3	1	0.13	46	6.2542	0.525
2015	7	15	14	6	52	0.3	1	0.15	65.1	6.2542	0.7422
2015	7	15	14	16	52	0.3	1	0.17	88.9	6.2735	0.9263
2015	7	15	14	26	52	0.3	1	0.16	81.7	6.2735	0.8718
2015	7	15	14	36	52	0.3	1	0.19	71.6	6.2929	0.984
2015	7	15	14	46	52	0.3	1	0.16	53.4	6.2929	0.7107
2015	7	15	14	56	52	0.3	1	0.16	51	6.2929	0.6742
2015	7	15	15	6	52	0.3	1	0.26	73.9	6.2929	1.3849
2015	7	15	15	16	52	0.3	1	0.19	53.5	6.3122	0.841

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	15	15	26	52	0.3	1	0.19	57.1	6.3122	0.8776
2015	7	15	15	36	52	0.3	1	0.22	63.8	6.3509	1.0858
2015	7	15	15	46	52	0.3	1	0.12	70	6.3509	0.6073
2015	7	15	15	56	52	0.3	1	0.16	69.7	6.3509	0.8465
2015	7	15	16	6	52	0.3	1	0.15	75.1	6.3703	0.8308
2015	7	15	16	16	52	0.3	1	0.2	79.4	6.3703	1.0893
2015	7	15	16	26	52	0.3	1	0.17	49	6.3703	0.7016
2015	7	15	16	36	52	0.3	1	0.14	80.3	6.3703	0.757
2015	7	15	16	46	52	0.3	1	0.18	78.3	6.3897	0.9817
2015	7	15	16	56	52	0.3	1	0.16	57.3	6.3897	0.778
2015	7	15	17	6	52	0.3	1	0.16	61.3	6.3897	0.778
2015	7	15	17	16	52	0.3	1	0.16	94.8	6.3897	0.8891
2015	7	15	17	26	52	0.3	1	0.19	107.5	6.409	1.0035
2015	7	15	17	36	52	0.3	1	0.18	48.7	6.409	0.7619
2015	7	15	17	46	52	0.3	1	0.21	58.6	6.409	1.0035
2015	7	15	17	56	52	0.3	1	0.26	81.1	6.409	1.4309
2015	7	15	18	6	52	0.3	1	0.18	93.2	6.4284	1.0068
2015	7	15	18	16	52	0.3	1	0.2	95.5	6.4284	1.1559
2015	7	15	18	26	52	0.3	1	0.18	74.9	6.4284	0.9695
2015	7	15	18	36	52	0.3	1	0.16	116.6	6.4284	0.8203
2015	7	15	18	46	52	0.3	1	0.21	79.4	6.4284	1.1932
2015	7	15	18	56	52	0.3	1	0.14	98.1	6.4477	0.7856
2015	7	15	19	6	52	0.3	1	0.1	131.2	6.4477	0.4489
2015	7	15	19	16	52	0.3	1	0.19	88.1	6.4477	1.1035
2015	7	15	19	26	52	0.3	1	0.14	74.6	6.4477	0.7482
2015	7	15	19	36	52	0.3	1	0.14	106.7	6.4477	0.7482
2015	7	15	19	46	52	0.3	1	0.11	102	6.4477	0.6172
2015	7	15	19	56	52	0.3	1	0.18	83.7	6.4477	1.01
2015	7	15	20	6	52	0.3	1	0.14	83.2	6.4477	0.7856
2015	7	15	20	16	52	0.3	1	0.15	91.2	6.4477	0.8604
2015	7	15	20	26	52	0.3	1	0.21	118.5	6.4477	1.0661
2015	7	15	20	36	52	0.3	1	0.24	106.7	6.4671	1.3135
2015	7	15	20	46	52	0.3	1	0.16	123	6.4671	0.7506
2015	7	15	20	56	52	0.3	1	0.18	83.7	6.4671	1.0133

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	15	21	6	52	0.3	1	0.18	108.4	6.4671	0.957
2015	7	15	21	16	52	0.3	1	0.19	94.9	6.4671	1.0883
2015	7	15	21	26	52	0.3	1	0.18	108.4	6.4671	0.957
2015	7	15	21	36	52	0.3	1	0.18	104.8	6.4671	0.9945
2015	7	15	21	46	52	0.3	1	0.22	100.5	6.4671	1.2197
2015	7	15	21	56	52	0.3	1	0.19	106.9	6.4671	1.0508
2015	7	15	22	6	52	0.3	1	0.2	82.3	6.4671	1.1071
2015	7	15	22	16	52	0.3	1	0.15	101.1	6.4671	0.8632
2015	7	15	22	26	52	0.3	1	0.11	90	6.4671	0.6192
2015	7	15	22	36	52	0.3	1	0.14	84.4	6.4671	0.7694
2015	7	15	22	46	52	0.3	1	0.18	80.4	6.4864	0.9977
2015	7	15	22	56	52	0.3	1	0.16	99.7	6.4864	0.8848
2015	7	15	23	6	52	0.3	1	0.2	91.9	6.4864	1.1295
2015	7	15	23	16	52	0.3	1	0.19	65.6	6.4864	0.9977
2015	7	15	23	26	52	0.3	1	0.21	92.7	6.4864	1.2048
2015	7	15	23	36	52	0.3	1	0.12	72.6	6.4864	0.6589
2015	7	15	23	46	52	0.3	1	0.17	95.6	6.5058	0.9632
2015	7	15	23	56	52	0.3	1	0.2	91.8	6.5058	1.1709
2015	7	16	0	6	52	0.3	1	0.21	77.5	6.5058	1.1898
2015	7	16	0	16	52	0.3	1	0.2	85.3	6.5058	1.152
2015	7	16	0	26	52	0.3	1	0.2	96.7	6.5252	1.1368
2015	7	16	0	36	52	0.3	1	0.19	92	6.5445	1.1024
2015	7	16	0	46	52	0.3	1	0.2	112.7	6.5445	1.0453
2015	7	16	0	56	52	0.3	1	0.15	81.3	6.5445	0.8743
2015	7	16	1	6	52	0.3	1	0.16	84.1	6.5445	0.9123
2015	7	16	1	16	52	0.3	1	0.19	97	6.5445	1.0834
2015	7	16	1	26	52	0.3	1	0.13	74.9	6.5639	0.7055
2015	7	16	1	36	52	0.3	1	0.2	113.6	6.5639	1.0487
2015	7	16	1	46	52	0.3	1	0.21	81.9	6.5639	1.2012
2015	7	16	1	56	52	0.3	1	0.3	89.4	6.5639	1.7351
2015	7	16	2	6	52	0.3	1	0.22	109.5	6.5639	1.1821
2015	7	16	2	16	52	0.3	1	0.25	105.1	6.5639	1.4109
2015	7	16	2	26	52	0.3	1	0.24	89.2	6.5639	1.3919
2015	7	16	2	36	52	0.3	1	0.23	105.8	6.5639	1.2775

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	16	2	46	52	0.3	1	0.19	118.8	6.5832	0.9755
2015	7	16	2	56	52	0.3	1	0.14	111	6.5639	0.7436
2015	7	16	3	6	52	0.3	1	0.17	86.6	6.5639	0.9724
2015	7	16	3	16	52	0.3	1	0.21	108.7	6.5832	1.1859
2015	7	16	3	26	52	0.3	1	0.24	86.1	6.5639	1.3919
2015	7	16	3	36	52	0.3	1	0.15	103.7	6.5832	0.8607
2015	7	16	3	46	52	0.3	1	0.17	113.6	6.5832	0.9181
2015	7	16	3	56	52	0.3	1	0.2	82.3	6.5832	1.1285
2015	7	16	4	6	52	0.3	1	0.12	81.9	6.5832	0.6695
2015	7	16	4	16	52	0.3	1	0.24	95.6	6.5832	1.3772
2015	7	16	4	26	52	0.3	1	0.14	103.4	6.5832	0.8034
2015	7	16	4	36	52	0.3	1	0.22	75.3	6.5832	1.2433
2015	7	16	4	46	52	0.3	1	0.18	93.2	6.5832	1.0329
2015	7	16	4	56	52	0.3	1	0.16	80.3	6.5832	0.899
2015	7	16	5	6	52	0.3	1	0.24	82	6.5832	1.3581
2015	7	16	5	16	52	0.3	1	0.18	95.3	6.5832	1.0329
2015	7	16	5	26	52	0.3	1	0.21	105.6	6.5832	1.1668
2015	7	16	5	36	52	0.3	1	0.12	94.6	6.5832	0.7077
2015	7	16	5	46	52	0.3	1	0.22	92.6	6.5832	1.2624
2015	7	16	5	56	52	0.3	1	0.22	99.6	6.5832	1.2433
2015	7	16	6	6	52	0.3	1	0.19	100	6.5832	1.0903
2015	7	16	6	16	52	0.3	1	0.22	87.4	6.5832	1.2624
2015	7	16	6	26	52	0.3	1	0.24	113.1	6.5832	1.3007
2015	7	16	6	36	52	0.3	1	0.16	62.4	6.5832	0.8416
2015	7	16	6	46	52	0.3	1	0.18	86.8	6.5832	1.0329
2015	7	16	6	56	52	0.3	1	0.16	76.6	6.5832	0.8799
2015	7	16	7	6	52	0.3	1	0.26	78.4	6.5832	1.492
2015	7	16	7	16	52	0.3	1	0.22	85.7	6.5832	1.2624
2015	7	16	7	26	52	0.3	1	0.17	102.4	6.5832	0.9564
2015	7	16	7	36	52	0.3	1	0.16	92.3	6.5832	0.9564
2015	7	16	7	46	52	0.3	1	0.14	80.3	6.5832	0.7842
2015	7	16	7	56	52	0.3	1	0.14	90	6.5832	0.8034
2015	7	16	8	6	52	0.3	1	0.22	93.4	6.5832	1.3007
2015	7	16	8	16	52	0.3	1	0.16	95.7	6.6026	0.9594

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	16	8	26	52	0.3	1	0.25	83.3	6.6026	1.4775
2015	7	16	8	36	52	0.3	1	0.11	116.6	6.6026	0.5756
2015	7	16	8	46	52	0.3	1	0.11	71	6.6026	0.614
2015	7	16	8	56	52	0.3	1	0.14	90	6.6026	0.8251
2015	7	16	9	6	52	0.3	1	0.16	90	6.5832	0.9181
2015	7	16	9	16	52	0.3	1	0.16	78	6.5832	0.899
2015	7	16	9	26	52	0.3	1	0.21	80.8	6.6026	1.1896
2015	7	16	9	36	52	0.3	1	0.28	78.6	6.6026	1.6118
2015	7	16	9	46	52	0.3	1	0.21	72.7	6.6026	1.1705
2015	7	16	9	56	52	0.3	1	0.14	90	6.6026	0.8251
2015	7	16	10	6	52	0.3	1	0.2	97.7	6.5832	1.1285
2015	7	16	10	16	52	0.3	1	0.18	85.8	6.6026	1.0553
2015	7	16	10	26	52	0.3	1	0.16	84.1	6.5832	0.9181
2015	7	16	10	36	52	0.3	1	0.22	90.8	6.5832	1.3007
2015	7	16	10	46	52	0.3	1	0.18	69.6	6.5832	0.9755
2015	7	16	10	56	52	0.3	1	0.22	75.3	6.5832	1.2433
2015	7	16	11	6	52	0.3	1	0.22	88.3	6.5832	1.2815
2015	7	16	11	16	52	0.3	1	0.16	76.6	6.5832	0.8799
2015	7	16	11	26	52	0.3	1	0.21	58.7	6.5832	1.0711
2015	7	16	11	36	52	0.3	1	0.18	83.7	6.5832	1.0329
2015	7	16	11	46	52	0.3	1	0.21	72.4	6.5832	1.1476
2015	7	16	11	56	52	0.3	1	0.25	76.3	6.5832	1.4154
2015	7	16	12	6	52	0.3	1	0.22	63.8	6.5832	1.1668
2015	7	16	12	16	52	0.3	1	0.14	61.6	6.5639	0.7055
2015	7	16	12	26	52	0.3	1	0.23	80.9	6.5639	1.3156
2015	7	16	12	36	52	0.3	1	0.23	64.9	6.5639	1.2203
2015	7	16	12	46	52	0.3	1	0.17	71.2	6.5639	0.9533
2015	7	16	12	56	52	0.3	1	0.16	74.5	6.5639	0.8961
2015	7	16	13	6	52	0.3	1	0.22	76.4	6.5639	1.2584
2015	7	16	13	16	52	0.3	1	0.26	59.5	6.5639	1.2965
2015	7	16	13	26	52	0.3	1	0.24	69.1	6.5445	1.2924
2015	7	16	13	36	52	0.3	1	0.24	77.5	6.5445	1.3684
2015	7	16	13	46	52	0.3	1	0.22	81.4	6.5445	1.2544
2015	7	16	13	56	52	0.3	1	0.22	68.4	6.5445	1.1974

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	16	14	6	52	0.3	1	0.23	70.5	6.5445	1.2354
2015	7	16	14	16	52	0.3	1	0.23	57.9	6.5445	1.1213
2015	7	16	14	26	52	0.3	1	0.28	54.5	6.5252	1.3262
2015	7	16	14	36	52	0.3	1	0.26	67.7	6.5252	1.383
2015	7	16	14	46	52	0.3	1	0.25	67.2	6.5252	1.3072
2015	7	16	14	56	52	0.3	1	0.25	73.7	6.5058	1.3597
2015	7	16	15	6	52	0.3	1	0.18	52.5	6.5058	0.8121
2015	7	16	15	16	52	0.3	1	0.24	60.9	6.5252	1.1935
2015	7	16	15	26	52	0.3	1	0.27	77.9	6.5252	1.4967
2015	7	16	15	36	52	0.3	1	0.23	76.6	6.5058	1.2653
2015	7	16	15	46	52	0.3	1	0.16	68.6	6.5252	0.8715
2015	7	16	15	56	52	0.3	1	0.25	57.4	6.5058	1.2086
2015	7	16	16	6	52	0.3	1	0.27	46	6.5058	1.1331
2015	7	16	16	16	52	0.3	1	0.21	59	6.5058	1.0387
2015	7	16	16	26	52	0.3	1	0.22	84.8	6.5058	1.2464
2015	7	16	16	36	52	0.3	1	0.16	62.4	6.5058	0.7932
2015	7	16	16	46	52	0.3	1	0.18	98.4	6.5058	1.0198
2015	7	16	16	56	52	0.3	1	0.2	50.2	6.5058	0.9065
2015	7	16	17	6	52	0.3	1	0.17	84.6	6.5058	1.0009
2015	7	16	17	16	52	0.3	1	0.14	75.3	6.5058	0.7932
2015	7	16	17	26	52	0.3	1	0.2	64.3	6.5058	1.0575
2015	7	16	17	36	52	0.3	1	0.18	79.5	6.5058	1.0198
2015	7	16	17	46	52	0.3	1	0.17	66.4	6.5058	0.9065
2015	7	16	17	56	52	0.3	1	0.18	80.7	6.5058	1.0387
2015	7	16	18	6	52	0.3	1	0.12	86.8	6.5058	0.6799
2015	7	16	18	16	52	0.3	1	0.24	76.5	6.5058	1.3408
2015	7	16	18	26	52	0.3	1	0.23	85.1	6.5058	1.3219
2015	7	16	18	36	52	0.3	1	0.16	100.8	6.5058	0.8876
2015	7	16	18	46	52	0.3	1	0.15	86.3	6.4864	0.8848
2015	7	16	18	56	52	0.3	1	0.25	84.8	6.5058	1.4541
2015	7	16	19	6	52	0.3	1	0.23	78.7	6.5058	1.3219
2015	7	16	19	16	52	0.3	1	0.17	102.4	6.5058	0.9442
2015	7	16	19	26	52	0.3	1	0.16	98.3	6.5058	0.9065
2015	7	16	19	36	52	0.3	1	0.13	114.7	6.5058	0.6987

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	16	19	46	52	0.3	1	0.18	105.5	6.5058	1.0198
2015	7	16	19	56	52	0.3	1	0.17	90	6.5058	0.982
2015	7	16	20	6	52	0.3	1	0.2	106.1	6.5058	1.1142
2015	7	16	20	16	52	0.3	1	0.18	103	6.5058	0.982
2015	7	16	20	26	52	0.3	1	0.21	102.7	6.5058	1.1709
2015	7	16	20	36	52	0.3	1	0.18	87.9	6.5058	1.0387
2015	7	16	20	46	52	0.3	1	0.26	92.2	6.5252	1.4777
2015	7	16	20	56	52	0.3	1	0.18	109.7	6.5252	1.0041
2015	7	16	21	6	52	0.3	1	0.19	110.9	6.5058	1.0387
2015	7	16	21	16	52	0.3	1	0.12	90	6.5058	0.6987
2015	7	16	21	26	52	0.3	1	0.26	89.3	6.5058	1.473
2015	7	16	21	36	52	0.3	1	0.26	86.4	6.5058	1.4919
2015	7	16	21	46	52	0.3	1	0.17	90	6.5252	1.0041
2015	7	16	21	56	52	0.3	1	0.24	101.6	6.5252	1.383
2015	7	16	22	6	52	0.3	1	0.18	97.5	6.5252	1.0041
2015	7	16	22	16	52	0.3	1	0.25	77.1	6.5252	1.402
2015	7	16	22	26	52	0.3	1	0.15	111.1	6.5252	0.8336
2015	7	16	22	36	52	0.3	1	0.14	74.6	6.5252	0.7578
2015	7	16	22	46	52	0.3	1	0.22	95.1	6.5445	1.2734
2015	7	16	22	56	52	0.3	1	0.21	95.3	6.5445	1.2354
2015	7	16	23	6	52	0.3	1	0.21	90	6.5445	1.1974
2015	7	16	23	16	52	0.3	1	0.17	94.4	6.5445	0.9883
2015	7	16	23	26	52	0.3	1	0.18	101.3	6.5445	1.0453
2015	7	16	23	36	52	0.3	1	0.15	95.1	6.5445	0.8553
2015	7	16	23	46	52	0.3	1	0.16	104.6	6.5445	0.8743
2015	7	16	23	56	52	0.3	1	0.14	65.9	6.5445	0.7222
2015	7	17	0	6	52	0.3	1	0.22	95.1	6.5445	1.2734
2015	7	17	0	16	52	0.3	1	0.23	93.3	6.5445	1.3304
2015	7	17	0	26	52	0.3	1	0.15	108	6.5445	0.8173
2015	7	17	0	36	52	0.3	1	0.25	86.2	6.5445	1.4255
2015	7	17	0	46	52	0.3	1	0.2	97.7	6.5445	1.1214
2015	7	17	0	56	52	0.3	1	0.24	100.1	6.5445	1.3875
2015	7	17	1	6	52	0.3	1	0.2	91.8	6.5445	1.1784
2015	7	17	1	16	52	0.3	1	0.2	107.5	6.5445	1.0834

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	17	1	26	52	0.3	1	0.15	83.8	6.5445	0.8743
2015	7	17	1	36	52	0.3	1	0.22	87.4	6.5445	1.2734
2015	7	17	1	46	52	0.3	1	0.18	109.4	6.5445	0.9693
2015	7	17	1	56	52	0.3	1	0.21	119	6.5445	1.0644
2015	7	17	2	6	52	0.3	1	0.15	79.9	6.5445	0.8553
2015	7	17	2	16	52	0.3	1	0.22	94.3	6.5445	1.2544
2015	7	17	2	26	52	0.3	1	0.14	106.3	6.5445	0.7793
2015	7	17	2	36	52	0.3	1	0.19	92	6.5252	1.0989
2015	7	17	2	46	52	0.3	1	0.18	102.3	6.5445	1.0454
2015	7	17	2	56	52	0.3	1	0.22	101	6.5252	1.2694
2015	7	17	3	6	52	0.3	1	0.23	99.2	6.5445	1.2925
2015	7	17	3	16	52	0.3	1	0.22	99.6	6.5252	1.2315
2015	7	17	3	26	52	0.3	1	0.16	108.4	6.5252	0.8526
2015	7	17	3	36	52	0.3	1	0.21	88.2	6.5445	1.1974
2015	7	17	3	46	52	0.3	1	0.19	104.7	6.5252	1.08
2015	7	17	3	56	52	0.3	1	0.19	100.7	6.5252	1.0989
2015	7	17	4	6	52	0.3	1	0.2	106.6	6.5252	1.08
2015	7	17	4	16	52	0.3	1	0.15	116.6	6.5252	0.7579
2015	7	17	4	26	52	0.3	1	0.24	94.7	6.5252	1.3831
2015	7	17	4	36	52	0.3	1	0.18	85.9	6.5252	1.061
2015	7	17	4	46	52	0.3	1	0.18	116.6	6.5252	0.9094
2015	7	17	4	56	52	0.3	1	0.18	106.8	6.5252	1.0042
2015	7	17	5	6	52	0.3	1	0.09	96.3	6.5252	0.5116
2015	7	17	5	16	52	0.3	1	0.2	86.2	6.5252	1.1368
2015	7	17	5	26	52	0.3	1	0.24	90	6.5252	1.3642
2015	7	17	5	36	52	0.3	1	0.14	110.6	6.5252	0.7579
2015	7	17	5	46	52	0.3	1	0.18	94.1	6.5252	1.061
2015	7	17	5	56	52	0.3	1	0.22	103.6	6.5252	1.2505
2015	7	17	6	6	52	0.3	1	0.15	98.7	6.5252	0.8716
2015	7	17	6	16	52	0.3	1	0.27	105.6	6.5252	1.4968
2015	7	17	6	26	52	0.3	1	0.12	107.9	6.5252	0.6442
2015	7	17	6	36	52	0.3	1	0.22	113.1	6.5058	1.1521
2015	7	17	6	46	52	0.3	1	0.22	76.8	6.5252	1.2126
2015	7	17	6	56	52	0.3	1	0.18	87.9	6.5252	1.0421

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	17	7	6	52	0.3	1	0.17	107.7	6.5252	0.9474
2015	7	17	7	16	52	0.3	1	0.16	93.5	6.5252	0.9284
2015	7	17	7	26	52	0.3	1	0.14	86.1	6.5252	0.8337
2015	7	17	7	36	52	0.3	1	0.15	105.6	6.5058	0.8121
2015	7	17	7	46	52	0.3	1	0.19	82.9	6.5058	1.0577
2015	7	17	7	56	52	0.3	1	0.12	105.9	6.5058	0.661
2015	7	17	8	6	52	0.3	1	0.19	103.3	6.5058	1.0388
2015	7	17	8	16	52	0.3	1	0.27	91.4	6.5058	1.5487
2015	7	17	8	26	52	0.3	1	0.17	90	6.5058	0.9632
2015	7	17	8	36	52	0.3	1	0.12	115.1	6.5058	0.6044
2015	7	17	8	46	52	0.3	1	0.23	90	6.5058	1.3221
2015	7	17	8	56	52	0.3	1	0.17	96.8	6.5058	0.9443
2015	7	17	9	6	52	0.3	1	0.2	90	6.5058	1.1521
2015	7	17	9	16	52	0.3	1	0.19	99.1	6.5058	1.0576
2015	7	17	9	26	52	0.3	1	0.2	89.1	6.4864	1.1672
2015	7	17	9	36	52	0.3	1	0.2	89.1	6.4864	1.1484
2015	7	17	9	46	52	0.3	1	0.16	76	6.4864	0.9037
2015	7	17	9	56	52	0.3	1	0.16	101.5	6.4864	0.9225
2015	7	17	10	6	52	0.3	1	0.2	67.7	6.4671	1.0509
2015	7	17	10	16	52	0.3	1	0.15	84.9	6.4671	0.8445
2015	7	17	10	26	52	0.3	1	0.23	94	6.4671	1.3324
2015	7	17	10	36	52	0.3	1	0.2	80.4	6.4671	1.1072
2015	7	17	10	46	52	0.3	1	0.14	62.9	6.4671	0.7319
2015	7	17	10	56	52	0.3	1	0.18	61.6	6.4671	0.9007
2015	7	17	11	6	52	0.3	1	0.22	71.6	6.4671	1.1822
2015	7	17	11	16	52	0.3	1	0.15	90	6.4671	0.882
2015	7	17	11	26	52	0.3	1	0.18	71.9	6.4671	0.9758
2015	7	17	11	36	52	0.3	1	0.2	59.7	6.4477	0.9914
2015	7	17	11	46	52	0.3	1	0.18	66.3	6.4477	0.9353
2015	7	17	11	56	52	0.3	1	0.23	74.2	6.4477	1.2533
2015	7	17	12	6	52	0.3	1	0.22	68	6.4477	1.1597
2015	7	17	12	16	52	0.3	1	0.22	72.1	6.4477	1.2158
2015	7	17	12	26	52	0.3	1	0.27	66.5	6.4477	1.4216
2015	7	17	12	36	52	0.3	1	0.22	61.9	6.4477	1.0849

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	17	12	46	52	0.3	1	0.19	68.4	6.4284	0.9882
2015	7	17	12	56	52	0.3	1	0.13	56.3	6.4284	0.6153
2015	7	17	13	6	52	0.3	1	0.16	62.4	6.4284	0.7831
2015	7	17	13	16	52	0.3	1	0.13	87.1	6.4477	0.7295
2015	7	17	13	26	52	0.3	1	0.2	76.4	6.4477	1.0849
2015	7	17	13	36	52	0.3	1	0.25	70.6	6.4477	1.328
2015	7	17	13	46	52	0.3	1	0.21	49.4	6.4477	0.9165
2015	7	17	13	56	52	0.3	1	0.06	84	6.4477	0.3554
2015	7	17	14	6	52	0.3	1	0.21	54.6	6.4477	0.9726
2015	7	17	14	16	52	0.3	1	0.23	56.5	6.4477	1.1036
2015	7	17	14	26	52	0.3	1	0.18	71.9	6.4477	0.9726
2015	7	17	14	36	52	0.3	1	0.22	75.6	6.4284	1.2305
2015	7	17	14	46	52	0.3	1	0.18	58.3	6.4477	0.8791
2015	7	17	14	56	52	0.3	1	0.21	64.6	6.4284	1.1
2015	7	17	15	6	52	0.3	1	0.18	70.3	6.4284	0.9881
2015	7	17	15	16	52	0.3	1	0.22	53	6.4477	0.9913
2015	7	17	15	26	52	0.3	1	0.17	70.5	6.4284	0.8949
2015	7	17	15	36	52	0.3	1	0.2	80.4	6.4284	1.1
2015	7	17	15	46	52	0.3	1	0.24	77.1	6.4284	1.3051
2015	7	17	15	56	52	0.3	1	0.17	68.4	6.4284	0.8949
2015	7	17	16	6	52	0.3	1	0.24	59.3	6.4284	1.1932
2015	7	17	16	16	52	0.3	1	0.17	52.2	6.4284	0.7458
2015	7	17	16	26	52	0.3	1	0.22	71.8	6.4284	1.1932
2015	7	17	16	36	52	0.3	1	0.16	62.4	6.4284	0.783
2015	7	17	16	46	52	0.3	1	0.15	57.7	6.4284	0.7085
2015	7	17	16	56	52	0.3	1	0.18	63	6.4284	0.9135
2015	7	17	17	6	52	0.3	1	0.22	90	6.4284	1.2305
2015	7	17	17	16	52	0.3	1	0.27	62.8	6.4284	1.3796
2015	7	17	17	26	52	0.3	1	0.26	81.4	6.4284	1.4729
2015	7	17	17	36	52	0.3	1	0.22	58.9	6.4284	1.0813
2015	7	17	17	46	52	0.3	1	0.16	70.1	6.4284	0.8763
2015	7	17	17	56	52	0.3	1	0.17	96.7	6.409	0.9478
2015	7	17	18	6	52	0.3	1	0.19	91.9	6.409	1.0964
2015	7	17	18	16	52	0.3	1	0.16	81.7	6.409	0.892

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	17	18	26	52	0.3	1	0.12	69.6	6.4284	0.6525
2015	7	17	18	36	52	0.3	1	0.2	100.4	6.409	1.115
2015	7	17	18	46	52	0.3	1	0.17	98	6.409	0.9292
2015	7	17	18	56	52	0.3	1	0.15	101.3	6.409	0.8363
2015	7	17	19	6	52	0.3	1	0.16	67.8	6.409	0.8177
2015	7	17	19	16	52	0.3	1	0.13	90	6.409	0.7433
2015	7	17	19	26	52	0.3	1	0.14	80.8	6.409	0.7991
2015	7	17	19	36	52	0.3	1	0.12	108.9	6.409	0.6504
2015	7	17	19	46	52	0.3	1	0.12	109.4	6.409	0.6318
2015	7	17	19	56	52	0.3	1	0.19	86	6.409	1.0593
2015	7	17	20	6	52	0.3	1	0.17	101.1	6.409	0.9478
2015	7	17	20	16	52	0.3	1	0.09	96.3	6.409	0.5018
2015	7	17	20	26	52	0.3	1	0.16	96.1	6.409	0.8734
2015	7	17	20	36	52	0.3	1	0.16	100.6	6.409	0.892
2015	7	17	20	46	52	0.3	1	0.19	105	6.409	1.0407
2015	7	17	20	56	52	0.3	1	0.19	84.1	6.409	1.0779
2015	7	17	21	6	52	0.3	1	0.2	107.2	6.409	1.0779
2015	7	17	21	16	52	0.3	1	0.16	109.9	6.409	0.8734
2015	7	17	21	26	52	0.3	1	0.18	100.5	6.409	1.0035
2015	7	17	21	36	52	0.3	1	0.1	131	6.409	0.4274
2015	7	17	21	46	52	0.3	1	0.17	64.4	6.3897	0.8521
2015	7	17	21	56	52	0.3	1	0.1	72.8	6.3897	0.5372
2015	7	17	22	6	52	0.3	1	0.17	76.5	6.3897	0.9262
2015	7	17	22	16	52	0.3	1	0.15	113.7	6.3897	0.7595
2015	7	17	22	26	52	0.3	1	0.16	81.7	6.3897	0.8891
2015	7	17	22	36	52	0.3	1	0.16	92.4	6.3897	0.8891
2015	7	17	22	46	52	0.3	1	0.14	105.4	6.3897	0.741
2015	7	17	22	56	52	0.3	1	0.16	92.4	6.3897	0.8891
2015	7	17	23	6	52	0.3	1	0.15	78.7	6.3897	0.8336
2015	7	17	23	16	52	0.3	1	0.17	96.7	6.3897	0.9447
2015	7	17	23	26	52	0.3	1	0.19	99	6.3897	1.0559
2015	7	17	23	36	52	0.3	1	0.18	87.9	6.3897	1.0188
2015	7	17	23	46	52	0.3	1	0.14	108	6.3897	0.741
2015	7	17	23	56	52	0.3	1	0.13	99	6.3897	0.7039

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	18	0	6	52	0.3	1	0.14	77.6	6.3897	0.7595
2015	7	18	0	16	52	0.3	1	0.08	118.6	6.3897	0.4075
2015	7	18	0	26	52	0.3	1	0.16	109.2	6.3897	0.8521
2015	7	18	0	36	52	0.3	1	0.18	94.2	6.3703	1.0155
2015	7	18	0	46	52	0.3	1	0.12	94.6	6.3703	0.6832
2015	7	18	0	56	52	0.3	1	0.15	93.7	6.3703	0.8678
2015	7	18	1	6	52	0.3	1	0.11	83.3	6.3703	0.6278
2015	7	18	1	16	52	0.3	1	0.16	95.8	6.3703	0.9047
2015	7	18	1	26	52	0.3	1	0.17	90	6.3703	0.9786
2015	7	18	1	36	52	0.3	1	0.13	100.4	6.3703	0.7016
2015	7	18	1	46	52	0.3	1	0.13	97.1	6.3703	0.7386
2015	7	18	1	56	52	0.3	1	0.15	68.9	6.3703	0.8124
2015	7	18	2	6	52	0.3	1	0.16	110.7	6.3703	0.8309
2015	7	18	2	16	52	0.3	1	0.2	112.3	6.3703	1.034
2015	7	18	2	26	52	0.3	1	0.02	99.5	6.3703	0.1108
2015	7	18	2	36	52	0.3	1	0.08	85.2	6.3703	0.4431
2015	7	18	2	46	52	0.3	1	0.19	93	6.3703	1.0525
2015	7	18	2	56	52	0.3	1	0.17	75.4	6.3509	0.9202
2015	7	18	3	6	52	0.3	1	0.15	118.3	6.3509	0.7178
2015	7	18	3	16	52	0.3	1	0.17	96.8	6.3509	0.9202
2015	7	18	3	26	52	0.3	1	0.12	126.3	6.3509	0.5521
2015	7	18	3	36	52	0.3	1	0.15	112.5	6.3509	0.7546
2015	7	18	3	46	52	0.3	1	0.19	117	6.3509	0.9386
2015	7	18	3	56	52	0.3	1	0.17	116.6	6.3509	0.8466
2015	7	18	4	6	52	0.3	1	0.16	112.4	6.3509	0.8466
2015	7	18	4	16	52	0.3	1	0.19	96	6.3509	1.049
2015	7	18	4	26	52	0.3	1	0.13	91.4	6.3509	0.7362
2015	7	18	4	36	52	0.3	1	0.14	71.1	6.3509	0.7546
2015	7	18	4	46	52	0.3	1	0.16	84.2	6.3509	0.9018
2015	7	18	4	56	52	0.3	1	0.18	79.3	6.3509	0.9754
2015	7	18	5	6	52	0.3	1	0.19	104.7	6.3509	1.0491
2015	7	18	5	16	52	0.3	1	0.16	77.3	6.3509	0.9018
2015	7	18	5	26	52	0.3	1	0.18	96.1	6.3509	1.0307
2015	7	18	5	36	52	0.3	1	0.08	73.7	6.3703	0.4432

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	18	5	46	52	0.3	1	0.12	94.9	6.3703	0.6463
2015	7	18	5	56	52	0.3	1	0.13	81.5	6.3703	0.7386
2015	7	18	6	6	52	0.3	1	0.08	59	6.3703	0.3693
2015	7	18	6	16	52	0.3	1	0.16	113.4	6.3703	0.8125
2015	7	18	6	26	52	0.3	1	0.09	126	6.3703	0.4062
2015	7	18	6	36	52	0.3	1	0.17	98.7	6.3703	0.9602
2015	7	18	6	46	52	0.3	1	0.19	90	6.3897	1.0745
2015	7	18	6	56	52	0.3	1	0.18	120.3	6.3897	0.8892
2015	7	18	7	6	52	0.3	1	0.13	107.5	6.3897	0.704
2015	7	18	7	16	52	0.3	1	0.19	104.3	6.3897	1.0189
2015	7	18	7	26	52	0.3	1	0.16	87.6	6.3897	0.8892
2015	7	18	7	36	52	0.3	1	0.08	101.3	6.3897	0.4631
2015	7	18	7	46	52	0.3	1	0.11	93.4	6.3897	0.6299
2015	7	18	7	56	52	0.3	1	0.1	119.1	6.409	0.5018
2015	7	18	8	6	52	0.3	1	0.15	123.3	6.409	0.7062
2015	7	18	8	16	52	0.3	1	0.17	71.9	6.409	0.9107
2015	7	18	8	26	52	0.3	1	0.23	91.6	6.409	1.301
2015	7	18	8	36	52	0.3	1	0.17	90	6.409	0.9664
2015	7	18	8	46	52	0.3	1	0.11	90	6.409	0.6319
2015	7	18	8	56	52	0.3	1	0.16	63.4	6.409	0.8177
2015	7	18	9	6	52	0.3	1	0.16	76.8	6.409	0.8735
2015	7	18	9	16	52	0.3	1	0.14	64.7	6.4284	0.7085
2015	7	18	9	26	52	0.3	1	0.11	81.1	6.4284	0.5967
2015	7	18	9	36	52	0.3	1	0.19	82.9	6.4284	1.0441
2015	7	18	9	46	52	0.3	1	0.16	54.7	6.4284	0.7645
2015	7	18	9	56	52	0.3	1	0.15	67.5	6.4284	0.7645
2015	7	18	10	6	52	0.3	1	0.17	83.2	6.4284	0.9323
2015	7	18	10	16	52	0.3	1	0.12	62.7	6.4284	0.6153
2015	7	18	10	26	52	0.3	1	0.21	80.8	6.4284	1.156
2015	7	18	10	36	52	0.3	1	0.17	77.6	6.4284	0.9323
2015	7	18	10	46	52	0.3	1	0.19	66.1	6.4284	0.9695
2015	7	18	10	56	52	0.3	1	0.18	67.2	6.4284	0.9323
2015	7	18	11	6	52	0.3	1	0.16	73.7	6.4284	0.895
2015	7	18	11	16	52	0.3	1	0.18	64.4	6.4284	0.9322

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	18	11	26	52	0.3	1	0.16	62.9	6.4284	0.8017
2015	7	18	11	36	52	0.3	1	0.18	61.6	6.4284	0.895
2015	7	18	11	46	52	0.3	1	0.23	60.9	6.4477	1.141
2015	7	18	11	56	52	0.3	1	0.14	66.4	6.4284	0.7272
2015	7	18	12	6	52	0.3	1	0.17	45	6.4284	0.6899
2015	7	18	12	16	52	0.3	1	0.2	74.2	6.4284	1.1187
2015	7	18	12	26	52	0.3	1	0.18	53.1	6.4477	0.823
2015	7	18	12	36	52	0.3	1	0.23	64.2	6.4477	1.1597
2015	7	18	12	46	52	0.3	1	0.21	64.6	6.4477	1.1036
2015	7	18	12	56	52	0.3	1	0.19	54.7	6.4477	0.8978
2015	7	18	13	6	52	0.3	1	0.29	64.6	6.4477	1.4964
2015	7	18	13	16	52	0.3	1	0.21	69.3	6.4477	1.141
2015	7	18	13	26	52	0.3	1	0.15	80.1	6.4477	0.8604
2015	7	18	13	36	52	0.3	1	0.17	46.6	6.4671	0.6943
2015	7	18	13	46	52	0.3	1	0.18	62.5	6.4671	0.9382
2015	7	18	13	56	52	0.3	1	0.22	76.4	6.4671	1.2385
2015	7	18	14	6	52	0.3	1	0.15	52.4	6.4477	0.6547
2015	7	18	14	16	52	0.3	1	0.22	66.1	6.4477	1.141
2015	7	18	14	26	52	0.3	1	0.18	52.3	6.4477	0.823
2015	7	18	14	36	52	0.3	1	0.2	43.7	6.4477	0.7856
2015	7	18	14	46	52	0.3	1	0.23	80.8	6.4671	1.276
2015	7	18	14	56	52	0.3	1	0.21	59	6.4477	1.0288
2015	7	18	15	6	52	0.3	1	0.24	60.3	6.4671	1.1822
2015	7	18	15	16	52	0.3	1	0.17	56.9	6.4477	0.8043
2015	7	18	15	26	52	0.3	1	0.14	75.3	6.4671	0.7881
2015	7	18	15	36	52	0.3	1	0.16	75.4	6.4671	0.8632
2015	7	18	15	46	52	0.3	1	0.21	67	6.4671	1.1071
2015	7	18	15	56	52	0.3	1	0.23	63.8	6.4671	1.1822
2015	7	18	16	6	52	0.3	1	0.26	66.3	6.4671	1.3698
2015	7	18	16	16	52	0.3	1	0.17	77.8	6.4671	0.957
2015	7	18	16	26	52	0.3	1	0.22	59.6	6.4864	1.0918
2015	7	18	16	36	52	0.3	1	0.18	80.4	6.4864	0.9977
2015	7	18	16	46	52	0.3	1	0.19	72.8	6.4864	1.0354
2015	7	18	16	56	52	0.3	1	0.15	62.3	6.4864	0.753

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	18	17	6	52	0.3	1	0.24	86.9	6.4864	1.3931
2015	7	18	17	16	52	0.3	1	0.17	84.5	6.5058	0.982
2015	7	18	17	26	52	0.3	1	0.24	68.6	6.5058	1.3031
2015	7	18	17	36	52	0.3	1	0.22	85.7	6.5058	1.2653
2015	7	18	17	46	52	0.3	1	0.11	98.4	6.5058	0.6421
2015	7	18	17	56	52	0.3	1	0.17	96.6	6.5252	0.9852
2015	7	18	18	6	52	0.3	1	0.25	92.3	6.5445	1.4445
2015	7	18	18	16	52	0.3	1	0.2	65.9	6.5445	1.0643
2015	7	18	18	26	52	0.3	1	0.2	120	6.5639	0.9915
2015	7	18	18	36	52	0.3	1	0.18	67.2	6.5639	0.9533
2015	7	18	18	46	52	0.3	1	0.19	100.9	6.5639	1.0868
2015	7	18	18	56	52	0.3	1	0.11	100.3	6.5639	0.6292
2015	7	18	19	6	52	0.3	1	0.18	97.5	6.5639	1.0105
2015	7	18	19	16	52	0.3	1	0.1	93.7	6.5832	0.5929
2015	7	18	19	26	52	0.3	1	0.25	111.3	6.5832	1.3771
2015	7	18	19	36	52	0.3	1	0.13	107.1	6.5832	0.7459
2015	7	18	19	46	52	0.3	1	0.19	107.2	6.5832	1.052
2015	7	18	19	56	52	0.3	1	0.17	95.6	6.5832	0.9755
2015	7	18	20	6	52	0.3	1	0.21	108.2	6.5832	1.1667
2015	7	18	20	16	52	0.3	1	0.15	90	6.5832	0.8607
2015	7	18	20	26	52	0.3	1	0.16	94.8	6.5832	0.9181
2015	7	18	20	36	52	0.3	1	0.16	62.9	6.6026	0.8251
2015	7	18	20	46	52	0.3	1	0.16	84.3	6.6026	0.9594
2015	7	18	20	56	52	0.3	1	0.26	108.7	6.6026	1.4199
2015	7	18	21	6	52	0.3	1	0.17	100.9	6.6026	0.9977
2015	7	18	21	16	52	0.3	1	0.24	86.1	6.6026	1.4199
2015	7	18	21	26	52	0.3	1	0.22	102.8	6.6026	1.2664
2015	7	18	21	36	52	0.3	1	0.15	97.4	6.6026	0.8826
2015	7	18	21	46	52	0.3	1	0.16	77.3	6.6026	0.9402
2015	7	18	21	56	52	0.3	1	0.18	85.9	6.6026	1.0745
2015	7	18	22	6	52	0.3	1	0.18	96.1	6.6026	1.0745
2015	7	18	22	16	52	0.3	1	0.16	97.1	6.6026	0.921
2015	7	18	22	26	52	0.3	1	0.19	101.7	6.6026	1.1129
2015	7	18	22	36	52	0.3	1	0.22	90.9	6.6026	1.2664

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	18	22	46	52	0.3	1	0.2	76.4	6.6026	1.1129
2015	7	18	22	56	52	0.3	1	0.21	82.9	6.6026	1.228
2015	7	18	23	6	52	0.3	1	0.23	100.7	6.6026	1.324
2015	7	18	23	16	52	0.3	1	0.15	76.3	6.6026	0.8635
2015	7	18	23	26	52	0.3	1	0.26	95	6.6026	1.535
2015	7	18	23	36	52	0.3	1	0.2	95.7	6.6026	1.1513
2015	7	18	23	46	52	0.3	1	0.18	96.1	6.6026	1.0745
2015	7	18	23	56	52	0.3	1	0.2	90	6.6026	1.1705
2015	7	19	0	6	52	0.3	1	0.14	100.8	6.6026	0.8059
2015	7	19	0	16	52	0.3	1	0.23	74.4	6.6026	1.3048
2015	7	19	0	26	52	0.3	1	0.21	100.8	6.6026	1.2088
2015	7	19	0	36	52	0.3	1	0.22	100.3	6.6219	1.2704
2015	7	19	0	46	52	0.3	1	0.21	98.9	6.6219	1.2319
2015	7	19	0	56	52	0.3	1	0.24	93.2	6.6219	1.3859
2015	7	19	1	6	52	0.3	1	0.12	79	6.6219	0.6929
2015	7	19	1	16	52	0.3	1	0.13	71.1	6.6219	0.7314
2015	7	19	1	26	52	0.3	1	0.13	81.5	6.6026	0.7675
2015	7	19	1	36	52	0.3	1	0.22	90	6.6026	1.2664
2015	7	19	1	46	52	0.3	1	0.21	107.9	6.6026	1.1897
2015	7	19	1	56	52	0.3	1	0.2	90	6.6219	1.1742
2015	7	19	2	6	52	0.3	1	0.17	121.9	6.6219	0.8662
2015	7	19	2	16	52	0.3	1	0.2	90	6.6219	1.1934
2015	7	19	2	26	52	0.3	1	0.27	80.9	6.6219	1.5591
2015	7	19	2	36	52	0.3	1	0.17	79.8	6.6219	0.9624
2015	7	19	2	46	52	0.3	1	0.23	83.6	6.6026	1.3624
2015	7	19	2	56	52	0.3	1	0.21	83.9	6.6219	1.2512
2015	7	19	3	6	52	0.3	1	0.27	75.8	6.6219	1.5207
2015	7	19	3	16	52	0.3	1	0.19	94.8	6.6026	1.1321
2015	7	19	3	26	52	0.3	1	0.17	88.9	6.6219	1.0009
2015	7	19	3	36	52	0.3	1	0.21	97.1	6.6219	1.2319
2015	7	19	3	46	52	0.3	1	0.22	95	6.6219	1.3089
2015	7	19	3	56	52	0.3	1	0.22	89.1	6.6219	1.2897
2015	7	19	4	6	52	0.3	1	0.12	108.4	6.6219	0.693
2015	7	19	4	16	52	0.3	1	0.19	102.1	6.6219	1.0779

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	19	4	26	52	0.3	1	0.21	89.1	6.6219	1.2319
2015	7	19	4	36	52	0.3	1	0.2	85.3	6.6219	1.1742
2015	7	19	4	46	52	0.3	1	0.21	96.1	6.6219	1.2512
2015	7	19	4	56	52	0.3	1	0.25	91.5	6.6219	1.4437
2015	7	19	5	6	52	0.3	1	0.25	112.2	6.6219	1.3667
2015	7	19	5	16	52	0.3	1	0.18	107.4	6.6219	0.9817
2015	7	19	5	26	52	0.3	1	0.21	101.8	6.6219	1.1934
2015	7	19	5	36	52	0.3	1	0.2	82.3	6.6219	1.1357
2015	7	19	5	46	52	0.3	1	0.21	87.3	6.6026	1.2281
2015	7	19	5	56	52	0.3	1	0.28	102.9	6.6219	1.5977
2015	7	19	6	6	52	0.3	1	0.28	94.7	6.6219	1.6362
2015	7	19	6	16	52	0.3	1	0.2	92.8	6.6026	1.1897
2015	7	19	6	26	52	0.3	1	0.18	102.3	6.6219	1.0587
2015	7	19	6	36	52	0.3	1	0.17	84.4	6.6219	0.9817
2015	7	19	6	46	52	0.3	1	0.18	96.1	6.6219	1.0779
2015	7	19	6	56	52	0.3	1	0.18	97.3	6.6219	1.0587
2015	7	19	7	6	52	0.3	1	0.25	110.1	6.6219	1.3667
2015	7	19	7	16	52	0.3	1	0.21	79.9	6.6219	1.1934
2015	7	19	7	26	52	0.3	1	0.15	118.3	6.6219	0.7507
2015	7	19	7	36	52	0.3	1	0.22	101.3	6.6219	1.2512
2015	7	19	7	46	52	0.3	1	0.18	94.2	6.6219	1.0587
2015	7	19	7	56	52	0.3	1	0.17	96.7	6.6219	0.9817
2015	7	19	8	6	52	0.3	1	0.22	86.6	6.6219	1.3089
2015	7	19	8	16	52	0.3	1	0.22	93.5	6.6219	1.2704
2015	7	19	8	26	52	0.3	1	0.22	92.6	6.6219	1.2704
2015	7	19	8	36	52	0.3	1	0.16	102.9	6.6219	0.9239
2015	7	19	8	46	52	0.3	1	0.2	86.2	6.6219	1.1549
2015	7	19	8	56	52	0.3	1	0.19	105.7	6.6219	1.0972
2015	7	19	9	6	52	0.3	1	0.21	71.8	6.6219	1.1742
2015	7	19	9	16	52	0.3	1	0.21	95.4	6.6219	1.2319
2015	7	19	9	26	52	0.3	1	0.17	73	6.6219	0.9432
2015	7	19	9	36	52	0.3	1	0.18	90	6.6219	1.0779
2015	7	19	9	46	52	0.3	1	0.23	94.1	6.6219	1.3281
2015	7	19	9	56	52	0.3	1	0.15	72.3	6.6219	0.8469

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	19	10	6	52	0.3	1	0.18	72.6	6.6219	0.9817
2015	7	19	10	16	52	0.3	1	0.13	73.9	6.6219	0.7314
2015	7	19	10	26	52	0.3	1	0.22	82.3	6.6219	1.2896
2015	7	19	10	36	52	0.3	1	0.24	91.6	6.6219	1.3859
2015	7	19	10	46	52	0.3	1	0.07	87.1	6.6219	0.385
2015	7	19	10	56	52	0.3	1	0.23	76.6	6.6219	1.2896
2015	7	19	11	6	52	0.3	1	0.12	108.9	6.6219	0.6737
2015	7	19	11	16	52	0.3	1	0.15	100.3	6.6219	0.8469
2015	7	19	11	26	52	0.3	1	0.2	63	6.6026	1.0553
2015	7	19	11	36	52	0.3	1	0.2	47	6.6219	0.8662
2015	7	19	11	46	52	0.3	1	0.16	82.7	6.6026	0.9018
2015	7	19	11	56	52	0.3	1	0.19	86.1	6.6026	1.1129
2015	7	19	12	6	52	0.3	1	0.18	69.6	6.6026	0.9786
2015	7	19	12	16	52	0.3	1	0.25	80	6.6026	1.4199
2015	7	19	12	26	52	0.3	1	0.22	72.6	6.6026	1.228
2015	7	19	12	36	52	0.3	1	0.18	83.9	6.6026	1.0745
2015	7	19	12	46	52	0.3	1	0.16	71.2	6.6026	0.9018
2015	7	19	12	56	52	0.3	1	0.2	74.2	6.6026	1.1513
2015	7	19	13	6	52	0.3	1	0.15	51.1	6.6026	0.6908
2015	7	19	13	16	52	0.3	1	0.18	78.3	6.6026	1.0169
2015	7	19	13	26	52	0.3	1	0.2	62.2	6.6026	1.0169
2015	7	19	13	36	52	0.3	1	0.2	71.3	6.6026	1.132
2015	7	19	13	46	52	0.3	1	0.21	68.2	6.6026	1.1512
2015	7	19	13	56	52	0.3	1	0.25	67.2	6.6026	1.3239
2015	7	19	14	6	52	0.3	1	0.27	76.5	6.6026	1.5158
2015	7	19	14	16	52	0.3	1	0.22	84	6.5832	1.2815
2015	7	19	14	26	52	0.3	1	0.18	71.9	6.6026	0.9977
2015	7	19	14	36	52	0.3	1	0.26	64.1	6.5832	1.3389
2015	7	19	14	46	52	0.3	1	0.18	90	6.6026	1.0553
2015	7	19	14	56	52	0.3	1	0.15	90	6.6026	0.9018
2015	7	19	15	6	52	0.3	1	0.21	64.6	6.6026	1.132
2015	7	19	15	16	52	0.3	1	0.16	72.3	6.5832	0.8989
2015	7	19	15	26	52	0.3	1	0.23	50.7	6.5832	1.052
2015	7	19	15	36	52	0.3	1	0.29	78.3	6.5832	1.664

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	19	15	46	52	0.3	1	0.23	62.3	6.5832	1.1667
2015	7	19	15	56	52	0.3	1	0.2	68.4	6.5832	1.1093
2015	7	19	16	6	52	0.3	1	0.21	82.8	6.5832	1.205
2015	7	19	16	16	52	0.3	1	0.19	79.1	6.5639	1.0868
2015	7	19	16	26	52	0.3	1	0.14	90	6.5832	0.8224
2015	7	19	16	36	52	0.3	1	0.23	107.9	6.5832	1.3006
2015	7	19	16	46	52	0.3	1	0.23	73.1	6.5832	1.2623
2015	7	19	16	56	52	0.3	1	0.21	79.4	6.5832	1.2241
2015	7	19	17	6	52	0.3	1	0.16	83	6.5832	0.9372
2015	7	19	17	16	52	0.3	1	0.17	83.3	6.5832	0.9754
2015	7	19	17	26	52	0.3	1	0.19	89	6.5832	1.1093
2015	7	19	17	36	52	0.3	1	0.2	83.6	6.5832	1.1858
2015	7	19	17	46	52	0.3	1	0.19	74.3	6.5639	1.0868
2015	7	19	17	56	52	0.3	1	0.17	81.1	6.5832	0.9754
2015	7	19	18	6	52	0.3	1	0.18	96.1	6.5832	1.0711
2015	7	19	18	16	52	0.3	1	0.2	88.2	6.5639	1.1821
2015	7	19	18	26	52	0.3	1	0.22	78.2	6.5832	1.2815
2015	7	19	18	36	52	0.3	1	0.25	92.3	6.5639	1.449
2015	7	19	18	46	52	0.3	1	0.17	86.8	6.5832	1.0137
2015	7	19	18	56	52	0.3	1	0.24	94.7	6.5832	1.3962
2015	7	19	19	6	52	0.3	1	0.28	102.4	6.5639	1.5634
2015	7	19	19	16	52	0.3	1	0.19	106.2	6.5832	1.052
2015	7	19	19	26	52	0.3	1	0.23	81.6	6.5832	1.3006
2015	7	19	19	36	52	0.3	1	0.28	103	6.5639	1.5634
2015	7	19	19	46	52	0.3	1	0.14	79.2	6.5639	0.8008
2015	7	19	19	56	52	0.3	1	0.24	106.2	6.5445	1.3114
2015	7	19	20	6	52	0.3	1	0.23	93.3	6.5639	1.3156
2015	7	19	20	16	52	0.3	1	0.18	97.5	6.5832	1.0137
2015	7	19	20	26	52	0.3	1	0.2	78.7	6.5832	1.1476
2015	7	19	20	36	52	0.3	1	0.23	80.9	6.5832	1.3197
2015	7	19	20	46	52	0.3	1	0.19	117.9	6.5832	0.9755
2015	7	19	20	56	52	0.3	1	0.15	119.9	6.5832	0.7651
2015	7	19	21	6	52	0.3	1	0.15	86.3	6.5832	0.8798
2015	7	19	21	16	52	0.3	1	0.18	97.5	6.5832	1.0137

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	19	21	26	52	0.3	1	0.2	109.9	6.5832	1.1093
2015	7	19	21	36	52	0.3	1	0.23	90	6.5832	1.3389
2015	7	19	21	46	52	0.3	1	0.24	98.8	6.5832	1.358
2015	7	19	21	56	52	0.3	1	0.21	94.5	6.5832	1.2241
2015	7	19	22	6	52	0.3	1	0.17	93.3	6.5832	0.9946
2015	7	19	22	16	52	0.3	1	0.1	126.9	6.5832	0.459
2015	7	19	22	26	52	0.3	1	0.23	95	6.5832	1.3198
2015	7	19	22	36	52	0.3	1	0.26	97.9	6.5832	1.511
2015	7	19	22	46	52	0.3	1	0.19	96	6.5832	1.0902
2015	7	19	22	56	52	0.3	1	0.28	87.3	6.5832	1.6067
2015	7	19	23	6	52	0.3	1	0.25	91.5	6.5832	1.4728
2015	7	19	23	16	52	0.3	1	0.22	76.2	6.5832	1.2433
2015	7	19	23	26	52	0.3	1	0.1	93.7	6.5832	0.5929
2015	7	19	23	36	52	0.3	1	0.13	108	6.5639	0.7055
2015	7	19	23	46	52	0.3	1	0.21	69.3	6.5832	1.1667
2015	7	19	23	56	52	0.3	1	0.32	67.7	6.5832	1.7214
2015	7	20	0	6	52	0.3	1	0.25	70.6	6.5832	1.358
2015	7	20	0	16	52	0.3	1	0.22	67.7	6.5832	1.1667
2015	7	20	0	26	52	0.3	1	0.16	67.1	6.5832	0.8607
2015	7	20	0	36	52	0.3	1	0.21	61.5	6.5832	1.0902
2015	7	20	0	46	52	0.3	1	0.22	59.9	6.5832	1.0902
2015	7	20	0	56	52	0.3	1	0.23	60.9	6.5832	1.1668
2015	7	20	1	6	52	0.3	1	0.26	56.5	6.5832	1.2433
2015	7	20	1	16	52	0.3	1	0.31	51.4	6.5832	1.4154
2015	7	20	1	26	52	0.3	1	0.29	55.1	6.5832	1.3963
2015	7	20	1	36	52	0.3	1	0.14	67.7	6.5832	0.746
2015	7	20	1	46	52	0.3	1	0.24	77.5	6.5832	1.3772
2015	7	20	1	56	52	0.3	1	0.24	59.9	6.6026	1.1896
2015	7	20	2	6	52	0.3	1	0.26	52.6	6.5832	1.2241
2015	7	20	2	16	52	0.3	1	0.36	58.3	6.6026	1.8036
2015	7	20	2	26	52	0.3	1	0.35	33.1	6.6026	1.1129
2015	7	20	2	36	52	0.3	1	0.33	43.8	6.6026	1.3431
2015	7	20	2	46	52	0.3	1	0.44	50.1	6.6026	1.9763
2015	7	20	2	56	52	0.3	1	0.46	41.2	6.6026	1.7653

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	20	3	6	52	0.3	1	0.38	48.5	6.6026	1.6693
2015	7	20	3	16	52	0.3	1	0.36	42.4	6.6026	1.4391
2015	7	20	3	26	52	0.3	1	0.45	29.2	6.6026	1.2856
2015	7	20	3	36	52	0.3	1	0.42	45	6.6026	1.7269
2015	7	20	3	46	52	0.3	1	0.41	26	6.6026	1.0553
2015	7	20	3	56	52	0.3	1	0.45	35	6.6026	1.5158
2015	7	20	4	6	52	0.3	1	0.37	42.5	6.6026	1.4583
2015	7	20	4	16	52	0.3	1	0.4	39	6.6026	1.4775
2015	7	20	4	26	52	0.3	1	0.37	31.7	6.6026	1.1513
2015	7	20	4	36	52	0.3	1	0.46	29.5	6.6026	1.324
2015	7	20	4	46	52	0.3	1	0.39	30.7	6.6026	1.1513
2015	7	20	4	56	52	0.3	1	0.32	36.2	6.6026	1.0937
2015	7	20	5	6	52	0.3	1	0.44	42.3	6.6026	1.7269
2015	7	20	5	16	52	0.3	1	0.4	27.2	6.6026	1.0745
2015	7	20	5	26	52	0.3	1	0.44	42.3	6.6026	1.7269
2015	7	20	5	36	52	0.3	1	0.32	35.3	6.6026	1.0745
2015	7	20	5	46	52	0.3	1	0.34	40.7	6.6219	1.2896
2015	7	20	5	56	52	0.3	1	0.36	41.7	6.6219	1.4051
2015	7	20	6	6	52	0.3	1	0.35	52.6	6.6219	1.6361
2015	7	20	6	16	52	0.3	1	0.38	53.5	6.6219	1.7708
2015	7	20	6	26	52	0.3	1	0.35	46.5	6.6219	1.4821
2015	7	20	6	36	52	0.3	1	0.3	54	6.6219	1.4051
2015	7	20	6	46	52	0.3	1	0.3	55.8	6.6219	1.4436
2015	7	20	6	56	52	0.3	1	0.23	71.1	6.6219	1.2896
2015	7	20	7	6	52	0.3	1	0.26	62.8	6.6219	1.3474
2015	7	20	7	16	52	0.3	1	0.21	54.4	6.6219	1.0202
2015	7	20	7	26	52	0.3	1	0.24	73.5	6.6219	1.3666
2015	7	20	7	36	52	0.3	1	0.25	66.5	6.6219	1.3281
2015	7	20	7	46	52	0.3	1	0.16	90	6.6219	0.9239
2015	7	20	7	56	52	0.3	1	0.23	94.1	6.6219	1.3281
2015	7	20	8	6	52	0.3	1	0.2	81.5	6.6219	1.1549
2015	7	20	8	16	52	0.3	1	0.17	96.8	6.6219	0.9624
2015	7	20	8	26	52	0.3	1	0.18	90	6.6219	1.0587
2015	7	20	8	36	52	0.3	1	0.2	88.1	6.6219	1.1549

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	20	8	46	52	0.3	1	0.16	94.6	6.6219	0.9624
2015	7	20	8	56	52	0.3	1	0.19	78.9	6.6219	1.0779
2015	7	20	9	6	52	0.3	1	0.21	74.4	6.6413	1.1778
2015	7	20	9	16	52	0.3	1	0.2	62.2	6.6219	1.0586
2015	7	20	9	26	52	0.3	1	0.24	91.6	6.6413	1.4095
2015	7	20	9	36	52	0.3	1	0.23	92.4	6.6413	1.3709
2015	7	20	9	46	52	0.3	1	0.15	77.5	6.6413	0.8689
2015	7	20	9	56	52	0.3	1	0.2	90.9	6.6413	1.1971
2015	7	20	10	6	52	0.3	1	0.23	67.8	6.6219	1.2704
2015	7	20	10	16	52	0.3	1	0.22	75.3	6.6219	1.2511
2015	7	20	10	26	52	0.3	1	0.19	81.2	6.6413	1.1199
2015	7	20	10	36	52	0.3	1	0.24	74.8	6.6413	1.3516
2015	7	20	10	46	52	0.3	1	0.26	86.4	6.6413	1.5254
2015	7	20	10	56	52	0.3	1	0.27	77.9	6.6413	1.5254
2015	7	20	11	6	52	0.3	1	0.17	70.9	6.6413	0.9461
2015	7	20	11	16	52	0.3	1	0.18	73.9	6.6413	1.004
2015	7	20	11	26	52	0.3	1	0.18	86.8	6.6413	1.0427
2015	7	20	11	36	52	0.3	1	0.17	117.6	6.6413	0.8882
2015	7	20	11	46	52	0.3	1	0.14	76	6.6413	0.7723
2015	7	20	11	56	52	0.3	1	0.22	77.8	6.6413	1.255
2015	7	20	12	6	52	0.3	1	0.2	70.1	6.6413	1.1199
2015	7	20	12	16	52	0.3	1	0.23	75.8	6.6413	1.2937
2015	7	20	12	26	52	0.3	1	0.23	80.8	6.6413	1.313
2015	7	20	12	36	52	0.3	1	0.19	72.8	6.6413	1.062
2015	7	20	12	46	52	0.3	1	0.2	73	6.6413	1.1392
2015	7	20	12	56	52	0.3	1	0.22	52.1	6.6413	1.0426
2015	7	20	13	6	52	0.3	1	0.21	70.2	6.6413	1.1778
2015	7	20	13	16	52	0.3	1	0.21	70.2	6.6413	1.1778
2015	7	20	13	26	52	0.3	1	0.22	73.2	6.6413	1.2164
2015	7	20	13	36	52	0.3	1	0.21	79	6.6413	1.1971
2015	7	20	13	46	52	0.3	1	0.21	105.6	6.6413	1.1778
2015	7	20	13	56	52	0.3	1	0.16	76.8	6.6413	0.9075
2015	7	20	14	6	52	0.3	1	0.17	77.8	6.6413	0.9847
2015	7	20	14	16	52	0.3	1	0.16	55	6.6413	0.7723

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	20	14	26	52	0.3	1	0.22	82.1	6.6413	1.255
2015	7	20	14	36	52	0.3	1	0.15	93.8	6.6413	0.8689
2015	7	20	14	46	52	0.3	1	0.23	57.7	6.6413	1.1585
2015	7	20	14	56	52	0.3	1	0.28	86	6.6413	1.6412
2015	7	20	15	6	52	0.3	1	0.27	77.5	6.6413	1.5639
2015	7	20	15	16	52	0.3	1	0.17	74.4	6.6413	0.9654
2015	7	20	15	26	52	0.3	1	0.22	90.9	6.6413	1.2743
2015	7	20	15	36	52	0.3	1	0.2	66.4	6.6219	1.0586
2015	7	20	15	46	52	0.3	1	0.24	82	6.6413	1.3709
2015	7	20	15	56	52	0.3	1	0.23	67.8	6.6413	1.2743
2015	7	20	16	6	52	0.3	1	0.24	74.8	6.6413	1.3516
2015	7	20	16	16	52	0.3	1	0.17	61.9	6.6413	0.8689
2015	7	20	16	26	52	0.3	1	0.2	82.5	6.6413	1.1778
2015	7	20	16	36	52	0.3	1	0.2	69.8	6.6413	1.1006
2015	7	20	16	46	52	0.3	1	0.25	68.5	6.6413	1.3709
2015	7	20	16	56	52	0.3	1	0.23	95.8	6.6413	1.3322
2015	7	20	17	6	52	0.3	1	0.19	79.1	6.6413	1.1006
2015	7	20	17	16	52	0.3	1	0.27	73.6	6.6413	1.506
2015	7	20	17	26	52	0.3	1	0.2	71.9	6.6413	1.1199
2015	7	20	17	36	52	0.3	1	0.22	82.1	6.6413	1.255
2015	7	20	17	46	52	0.3	1	0.18	64.4	6.6413	0.9654
2015	7	20	17	56	52	0.3	1	0.19	87.1	6.6413	1.1392
2015	7	20	18	6	52	0.3	1	0.19	75.3	6.6413	1.1006
2015	7	20	18	16	52	0.3	1	0.12	77.8	6.6413	0.7144
2015	7	20	18	26	52	0.3	1	0.24	74.3	6.6413	1.3709
2015	7	20	18	36	52	0.3	1	0.18	78.5	6.6413	1.0426
2015	7	20	18	46	52	0.3	1	0.17	81.3	6.6026	0.9977
2015	7	20	18	56	52	0.3	1	0.29	75.7	6.6413	1.6605
2015	7	20	19	6	52	0.3	1	0.26	60.9	6.6413	1.3516
2015	7	20	19	16	52	0.3	1	0.24	64.1	6.6413	1.2743
2015	7	20	19	26	52	0.3	1	0.23	61.3	6.6413	1.1971
2015	7	20	19	36	52	0.3	1	0.21	73	6.6413	1.1971
2015	7	20	19	46	52	0.3	1	0.32	81	6.6413	1.8343
2015	7	20	19	56	52	0.3	1	0.22	81.4	6.6413	1.2743

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	20	20	6	52	0.3	1	0.22	63	6.6413	1.1392
2015	7	20	20	16	52	0.3	1	0.21	101.5	6.6413	1.2357
2015	7	20	20	26	52	0.3	1	0.24	106.2	6.6413	1.3322
2015	7	20	20	36	52	0.3	1	0.22	87.4	6.6413	1.2743
2015	7	20	20	46	52	0.3	1	0.23	80.1	6.6413	1.3323
2015	7	20	20	56	52	0.3	1	0.24	87.6	6.6413	1.4095
2015	7	20	21	6	52	0.3	1	0.17	90	6.6413	1.0233
2015	7	20	21	16	52	0.3	1	0.28	87.3	6.6413	1.6605
2015	7	20	21	26	52	0.3	1	0.16	65	6.6413	0.8689
2015	7	20	21	36	52	0.3	1	0.19	72.2	6.6413	1.0812
2015	7	20	21	46	52	0.3	1	0.24	83.7	6.6413	1.4095
2015	7	20	21	56	52	0.3	1	0.21	90	6.6413	1.2164
2015	7	20	22	6	52	0.3	1	0.23	85	6.6413	1.3323
2015	7	20	22	16	52	0.3	1	0.28	85.2	6.6413	1.6219
2015	7	20	22	26	52	0.3	1	0.19	95.9	6.6413	1.1199
2015	7	20	22	36	52	0.3	1	0.24	90	6.6413	1.4288
2015	7	20	22	46	52	0.3	1	0.24	92.4	6.6413	1.4095
2015	7	20	22	56	52	0.3	1	0.16	124	6.6413	0.7723
2015	7	20	23	6	52	0.3	1	0.24	94.6	6.6413	1.4288
2015	7	20	23	16	52	0.3	1	0.24	79.9	6.6413	1.4095
2015	7	20	23	26	52	0.3	1	0.22	84	6.6413	1.2937
2015	7	20	23	36	52	0.3	1	0.24	103.3	6.6413	1.3902
2015	7	20	23	46	52	0.3	1	0.19	104.7	6.6413	1.1006
2015	7	20	23	56	52	0.3	1	0.24	97.1	6.6413	1.3902
2015	7	21	0	6	52	0.3	1	0.23	80.8	6.6413	1.313
2015	7	21	0	16	52	0.3	1	0.17	100.2	6.6607	0.9684
2015	7	21	0	26	52	0.3	1	0.16	87.7	6.6607	0.9684
2015	7	21	0	36	52	0.3	1	0.2	85.4	6.6413	1.1971
2015	7	21	0	46	52	0.3	1	0.24	98.6	6.6413	1.4095
2015	7	21	0	56	52	0.3	1	0.23	86	6.6607	1.3752
2015	7	21	1	6	52	0.3	1	0.24	86.9	6.6413	1.4095
2015	7	21	1	16	52	0.3	1	0.22	94.3	6.6413	1.2937
2015	7	21	1	26	52	0.3	1	0.22	102.2	6.6607	1.259
2015	7	21	1	36	52	0.3	1	0.23	90	6.6413	1.3709

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	21	1	46	52	0.3	1	0.18	90	6.6413	1.0427
2015	7	21	1	56	52	0.3	1	0.22	90	6.6413	1.313
2015	7	21	2	6	52	0.3	1	0.14	78.2	6.6413	0.8303
2015	7	21	2	16	52	0.3	1	0.18	95.1	6.6413	1.0813
2015	7	21	2	26	52	0.3	1	0.23	96.6	6.6607	1.3365
2015	7	21	2	36	52	0.3	1	0.26	97.3	6.6413	1.5061
2015	7	21	2	46	52	0.3	1	0.18	93.1	6.6413	1.0813
2015	7	21	2	56	52	0.3	1	0.22	92.6	6.6413	1.2744
2015	7	21	3	6	52	0.3	1	0.23	93.3	6.6413	1.3516
2015	7	21	3	16	52	0.3	1	0.17	84.6	6.6413	1.0234
2015	7	21	3	26	52	0.3	1	0.24	86.1	6.6413	1.4095
2015	7	21	3	36	52	0.3	1	0.23	98.9	6.6413	1.3516
2015	7	21	3	46	52	0.3	1	0.21	90	6.6413	1.2358
2015	7	21	3	56	52	0.3	1	0.19	92.9	6.6413	1.1392
2015	7	21	4	6	52	0.3	1	0.16	90	6.6413	0.9654
2015	7	21	4	16	52	0.3	1	0.24	100.4	6.6413	1.3709
2015	7	21	4	26	52	0.3	1	0.23	90	6.6413	1.3323
2015	7	21	4	36	52	0.3	1	0.18	117	6.6413	0.9461
2015	7	21	4	46	52	0.3	1	0.18	94.1	6.6413	1.0813
2015	7	21	4	56	52	0.3	1	0.22	99.3	6.6413	1.2937
2015	7	21	5	6	52	0.3	1	0.2	96.7	6.6413	1.1585
2015	7	21	5	16	52	0.3	1	0.22	102.2	6.6413	1.2551
2015	7	21	5	26	52	0.3	1	0.16	95.7	6.6413	0.9654
2015	7	21	5	36	52	0.3	1	0.21	117.8	6.6413	1.1006
2015	7	21	5	46	52	0.3	1	0.22	112.4	6.6413	1.2165
2015	7	21	5	56	52	0.3	1	0.17	98.7	6.6413	1.0041
2015	7	21	6	6	52	0.3	1	0.18	92	6.6413	1.0813
2015	7	21	6	16	52	0.3	1	0.25	112.9	6.6413	1.3709
2015	7	21	6	26	52	0.3	1	0.21	97.4	6.6413	1.1972
2015	7	21	6	36	52	0.3	1	0.18	94.2	6.6413	1.062
2015	7	21	6	46	52	0.3	1	0.2	85.2	6.6413	1.1585
2015	7	21	6	56	52	0.3	1	0.14	71.1	6.6413	0.7917
2015	7	21	7	6	52	0.3	1	0.19	95	6.6413	1.1006
2015	7	21	7	16	52	0.3	1	0.23	94	6.6413	1.3709

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	21	7	26	52	0.3	1	0.17	102.4	6.6413	0.9654
2015	7	21	7	36	52	0.3	1	0.2	97.5	6.6413	1.1778
2015	7	21	7	46	52	0.3	1	0.22	100.5	6.6413	1.2551
2015	7	21	7	56	52	0.3	1	0.12	77.1	6.6413	0.6758
2015	7	21	8	6	52	0.3	1	0.2	96.5	6.6413	1.1778
2015	7	21	8	16	52	0.3	1	0.15	102.5	6.6413	0.8689
2015	7	21	8	26	52	0.3	1	0.21	99.2	6.6413	1.1971
2015	7	21	8	36	52	0.3	1	0.21	81	6.6413	1.2165
2015	7	21	8	46	52	0.3	1	0.18	97.3	6.6413	1.062
2015	7	21	8	56	52	0.3	1	0.23	94.9	6.6413	1.3516
2015	7	21	9	6	52	0.3	1	0.15	90	6.6413	0.8882
2015	7	21	9	16	52	0.3	1	0.16	78.2	6.6413	0.9268
2015	7	21	9	26	52	0.3	1	0.19	76	6.6413	1.0813
2015	7	21	9	36	52	0.3	1	0.2	95.5	6.6413	1.1971
2015	7	21	9	46	52	0.3	1	0.21	95.4	6.6413	1.2164
2015	7	21	9	56	52	0.3	1	0.25	83.2	6.6413	1.4481
2015	7	21	10	6	52	0.3	1	0.17	77.6	6.6413	0.9654
2015	7	21	10	16	52	0.3	1	0.21	77.3	6.6413	1.1971
2015	7	21	10	26	52	0.3	1	0.2	88.1	6.6413	1.1778
2015	7	21	10	36	52	0.3	1	0.24	71.6	6.6413	1.3323
2015	7	21	10	46	52	0.3	1	0.17	86.6	6.6413	0.9847
2015	7	21	10	56	52	0.3	1	0.24	90	6.6413	1.3902
2015	7	21	11	6	52	0.3	1	0.16	71.2	6.6413	0.9075
2015	7	21	11	16	52	0.3	1	0.23	80.8	6.6219	1.3089
2015	7	21	11	26	52	0.3	1	0.22	74.7	6.6219	1.2704
2015	7	21	11	36	52	0.3	1	0.19	62.6	6.6219	1.0009
2015	7	21	11	46	52	0.3	1	0.13	45	6.6219	0.5389
2015	7	21	11	56	52	0.3	1	0.25	76.1	6.6219	1.4051
2015	7	21	12	6	52	0.3	1	0.15	88.8	6.6219	0.9047
2015	7	21	12	16	52	0.3	1	0.24	82.9	6.6219	1.3859
2015	7	21	12	26	52	0.3	1	0.14	76.6	6.6219	0.8084
2015	7	21	12	36	52	0.3	1	0.15	64.5	6.6219	0.8084
2015	7	21	12	46	52	0.3	1	0.27	70.3	6.6026	1.4966
2015	7	21	12	56	52	0.3	1	0.21	82.9	6.6219	1.2319

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	21	13	6	52	0.3	1	0.2	95.5	6.6026	1.1896
2015	7	21	13	16	52	0.3	1	0.21	64.2	6.6219	1.1164
2015	7	21	13	26	52	0.3	1	0.24	76.5	6.6219	1.3666
2015	7	21	13	36	52	0.3	1	0.23	70.8	6.6219	1.2703
2015	7	21	13	46	52	0.3	1	0.18	82.7	6.6219	1.0586
2015	7	21	13	56	52	0.3	1	0.21	74.4	6.6026	1.1704
2015	7	21	14	6	52	0.3	1	0.2	73.7	6.6026	1.1128
2015	7	21	14	16	52	0.3	1	0.25	61.4	6.6026	1.3047
2015	7	21	14	26	52	0.3	1	0.19	69.7	6.6219	1.0393
2015	7	21	14	36	52	0.3	1	0.25	62.1	6.6026	1.2663
2015	7	21	14	46	52	0.3	1	0.18	71.9	6.6026	0.9977
2015	7	21	14	56	52	0.3	1	0.17	71.2	6.6026	0.9593
2015	7	21	15	6	52	0.3	1	0.28	65.5	6.6026	1.5157
2015	7	21	15	16	52	0.3	1	0.18	90	6.6026	1.0553
2015	7	21	15	26	52	0.3	1	0.19	91	6.6026	1.1128
2015	7	21	15	36	52	0.3	1	0.13	73.9	6.6026	0.7291
2015	7	21	15	46	52	0.3	1	0.21	122.5	6.6026	1.0553
2015	7	21	15	56	52	0.3	1	0.17	77.6	6.6026	0.9593
2015	7	21	16	6	52	0.3	1	0.13	82.7	6.6026	0.7483
2015	7	21	16	16	52	0.3	1	0.18	77	6.6026	0.9977
2015	7	21	16	26	52	0.3	1	0.15	75.1	6.6026	0.8634
2015	7	21	16	36	52	0.3	1	0.18	83.7	6.6026	1.0361
2015	7	21	16	46	52	0.3	1	0.19	89	6.6026	1.1128
2015	7	21	16	56	52	0.3	1	0.17	78.9	6.6026	0.9785
2015	7	21	17	6	52	0.3	1	0.15	77.7	6.6026	0.8826
2015	7	21	17	16	52	0.3	1	0.25	93	6.6026	1.4582
2015	7	21	17	26	52	0.3	1	0.17	93.2	6.6026	1.0169
2015	7	21	17	36	52	0.3	1	0.14	68.2	6.6026	0.7675
2015	7	21	17	46	52	0.3	1	0.18	100.5	6.5832	1.0328
2015	7	21	17	56	52	0.3	1	0.25	78.8	6.5832	1.4536
2015	7	21	18	6	52	0.3	1	0.24	82.2	6.5832	1.3962
2015	7	21	18	16	52	0.3	1	0.19	93	6.5639	1.1058
2015	7	21	18	26	52	0.3	1	0.24	86.9	6.6026	1.4198
2015	7	21	18	36	52	0.3	1	0.22	86.6	6.6026	1.2855

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	21	18	46	52	0.3	1	0.21	68.7	6.6026	1.132
2015	7	21	18	56	52	0.3	1	0.23	90	6.5832	1.3197
2015	7	21	19	6	52	0.3	1	0.25	87.7	6.5832	1.4345
2015	7	21	19	16	52	0.3	1	0.21	77.3	6.5832	1.1858
2015	7	21	19	26	52	0.3	1	0.23	111.8	6.5832	1.2432
2015	7	21	19	36	52	0.3	1	0.24	100.1	6.5832	1.3962
2015	7	21	19	46	52	0.3	1	0.21	104.5	6.5832	1.1858
2015	7	21	19	56	52	0.3	1	0.27	91.4	6.5639	1.5443
2015	7	21	20	6	52	0.3	1	0.21	93.6	6.5832	1.2241
2015	7	21	20	16	52	0.3	1	0.19	96	6.5832	1.0902
2015	7	21	20	26	52	0.3	1	0.24	90	6.5832	1.3771
2015	7	21	20	36	52	0.3	1	0.15	101.1	6.5832	0.8798
2015	7	21	20	46	52	0.3	1	0.25	67.2	6.5639	1.3156
2015	7	21	20	56	52	0.3	1	0.23	76.6	6.5832	1.2815
2015	7	21	21	6	52	0.3	1	0.21	82.9	6.5832	1.2241
2015	7	21	21	16	52	0.3	1	0.18	80.4	6.5832	1.0137
2015	7	21	21	26	52	0.3	1	0.25	84.8	6.5832	1.4727
2015	7	21	21	36	52	0.3	1	0.26	71.8	6.5832	1.4536
2015	7	21	21	46	52	0.3	1	0.27	79.4	6.5832	1.5301
2015	7	21	21	56	52	0.3	1	0.19	102.1	6.5832	1.0711
2015	7	21	22	6	52	0.3	1	0.17	93.4	6.5832	0.9755
2015	7	21	22	16	52	0.3	1	0.19	85.1	6.5832	1.1093
2015	7	21	22	26	52	0.3	1	0.21	90	6.5832	1.2432
2015	7	21	22	36	52	0.3	1	0.19	90	6.5832	1.0902
2015	7	21	22	46	52	0.3	1	0.2	91.9	6.5832	1.1476
2015	7	21	22	56	52	0.3	1	0.14	101.8	6.5832	0.8224
2015	7	21	23	6	52	0.3	1	0.12	115.2	6.5832	0.6503
2015	7	21	23	16	52	0.3	1	0.16	91.2	6.6026	0.9402
2015	7	21	23	26	52	0.3	1	0.22	112.3	6.5832	1.1667
2015	7	21	23	36	52	0.3	1	0.22	69.9	6.6026	1.2088
2015	7	21	23	46	52	0.3	1	0.19	88	6.5832	1.0902
2015	7	21	23	56	52	0.3	1	0.2	93.8	6.5832	1.1476
2015	7	22	0	6	52	0.3	1	0.17	85.6	6.6026	0.9977
2015	7	22	0	16	52	0.3	1	0.14	101.8	6.5832	0.8225

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	22	0	26	52	0.3	1	0.2	76.9	6.5832	1.1476
2015	7	22	0	36	52	0.3	1	0.22	90	6.5832	1.3006
2015	7	22	0	46	52	0.3	1	0.21	97.4	6.5832	1.1859
2015	7	22	0	56	52	0.3	1	0.21	81.1	6.5832	1.2241
2015	7	22	1	6	52	0.3	1	0.2	99.6	6.6026	1.1321
2015	7	22	1	16	52	0.3	1	0.19	83.1	6.6026	1.1129
2015	7	22	1	26	52	0.3	1	0.2	90	6.5832	1.1476
2015	7	22	1	36	52	0.3	1	0.2	84.4	6.5832	1.1668
2015	7	22	1	46	52	0.3	1	0.2	87.2	6.5832	1.1668
2015	7	22	1	56	52	0.3	1	0.18	102.5	6.5832	1.0329
2015	7	22	2	6	52	0.3	1	0.17	101.1	6.5832	0.9755
2015	7	22	2	16	52	0.3	1	0.21	85.6	6.5832	1.2433
2015	7	22	2	26	52	0.3	1	0.19	98.1	6.5832	1.0711
2015	7	22	2	36	52	0.3	1	0.18	70.3	6.5832	1.0137
2015	7	22	2	46	52	0.3	1	0.15	104.9	6.5832	0.8607
2015	7	22	2	56	52	0.3	1	0.11	95.2	6.6026	0.6332
2015	7	22	3	6	52	0.3	1	0.1	86.3	6.6026	0.5948
2015	7	22	3	16	52	0.3	1	0.16	90	6.6026	0.9594
2015	7	22	3	26	52	0.3	1	0.19	86.1	6.5832	1.1094
2015	7	22	3	36	52	0.3	1	0.22	80.5	6.6026	1.2664
2015	7	22	3	46	52	0.3	1	0.16	106.9	6.6026	0.8826
2015	7	22	3	56	52	0.3	1	0.16	101.5	6.6026	0.9402
2015	7	22	4	6	52	0.3	1	0.21	82.6	6.6026	1.1896
2015	7	22	4	16	52	0.3	1	0.23	104.2	6.6026	1.2856
2015	7	22	4	26	52	0.3	1	0.19	76	6.6026	1.0745
2015	7	22	4	36	52	0.3	1	0.22	96	6.6026	1.2856
2015	7	22	4	46	52	0.3	1	0.22	108.4	6.6026	1.2088
2015	7	22	4	56	52	0.3	1	0.11	90	6.6026	0.6524
2015	7	22	5	6	52	0.3	1	0.18	92	6.6026	1.0745
2015	7	22	5	16	52	0.3	1	0.22	86.6	6.6026	1.3048
2015	7	22	5	26	52	0.3	1	0.19	87	6.6026	1.0937
2015	7	22	5	36	52	0.3	1	0.26	95.1	6.6026	1.4967
2015	7	22	5	46	52	0.3	1	0.17	96.6	6.6026	0.9978
2015	7	22	5	56	52	0.3	1	0.2	96.5	6.6026	1.1705

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	22	6	6	52	0.3	1	0.19	88	6.6026	1.1129
2015	7	22	6	16	52	0.3	1	0.22	91.7	6.6026	1.2664
2015	7	22	6	26	52	0.3	1	0.17	85.7	6.6026	1.017
2015	7	22	6	36	52	0.3	1	0.18	122.2	6.6219	0.8854
2015	7	22	6	46	52	0.3	1	0.24	86.9	6.6026	1.4007
2015	7	22	6	56	52	0.3	1	0.17	98.7	6.6026	0.9978
2015	7	22	7	6	52	0.3	1	0.2	113.7	6.6219	1.0972
2015	7	22	7	16	52	0.3	1	0.17	82.2	6.6219	0.9817
2015	7	22	7	26	52	0.3	1	0.16	83.9	6.6026	0.9018
2015	7	22	7	36	52	0.3	1	0.24	84.5	6.6219	1.4051
2015	7	22	7	46	52	0.3	1	0.27	87.9	6.6219	1.5591
2015	7	22	7	56	52	0.3	1	0.22	102.2	6.6219	1.2511
2015	7	22	8	6	52	0.3	1	0.23	105.8	6.6219	1.2896
2015	7	22	8	16	52	0.3	1	0.18	96.2	6.6219	1.0587
2015	7	22	8	26	52	0.3	1	0.19	59.9	6.6219	0.9624
2015	7	22	8	36	52	0.3	1	0.24	83	6.6219	1.4051
2015	7	22	8	46	52	0.3	1	0.21	97.4	6.6219	1.1934
2015	7	22	8	56	52	0.3	1	0.18	102.5	6.6219	1.0394
2015	7	22	9	6	52	0.3	1	0.17	93.3	6.6219	1.0009
2015	7	22	9	16	52	0.3	1	0.22	92.6	6.6219	1.2704
2015	7	22	9	26	52	0.3	1	0.2	90.9	6.6219	1.1741
2015	7	22	9	36	52	0.3	1	0.21	82.9	6.6219	1.2319
2015	7	22	9	46	52	0.3	1	0.13	76.7	6.6219	0.7314
2015	7	22	9	56	52	0.3	1	0.27	104.7	6.6219	1.5398
2015	7	22	10	6	52	0.3	1	0.24	86.1	6.6219	1.4051
2015	7	22	10	16	52	0.3	1	0.19	91	6.6219	1.1356
2015	7	22	10	26	52	0.3	1	0.22	76	6.6219	1.2319
2015	7	22	10	36	52	0.3	1	0.21	94.5	6.6219	1.2126
2015	7	22	10	46	52	0.3	1	0.22	95	6.6219	1.3089
2015	7	22	10	56	52	0.3	1	0.11	81.4	6.6219	0.6352
2015	7	22	11	6	52	0.3	1	0.22	89.2	6.6219	1.3088
2015	7	22	11	16	52	0.3	1	0.19	81	6.6219	1.0971
2015	7	22	11	26	52	0.3	1	0.17	82	6.6026	0.9594
2015	7	22	11	36	52	0.3	1	0.21	74.7	6.6026	1.1896

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	22	11	46	52	0.3	1	0.21	93.6	6.6026	1.2088
2015	7	22	11	56	52	0.3	1	0.26	73.9	6.6026	1.4582
2015	7	22	12	6	52	0.3	1	0.18	84.9	6.6026	1.0745
2015	7	22	12	16	52	0.3	1	0.27	71.3	6.6026	1.4774
2015	7	22	12	26	52	0.3	1	0.26	74.7	6.6026	1.4774
2015	7	22	12	36	52	0.3	1	0.19	48.4	6.5832	0.8416
2015	7	22	12	46	52	0.3	1	0.19	55.8	6.6026	0.9018
2015	7	22	12	56	52	0.3	1	0.19	80.2	6.5832	1.1094
2015	7	22	13	6	52	0.3	1	0.23	54.3	6.6026	1.0937
2015	7	22	13	16	52	0.3	1	0.22	83.3	6.5832	1.3006
2015	7	22	13	26	52	0.3	1	0.24	59.6	6.6026	1.2088
2015	7	22	13	36	52	0.3	1	0.25	59.7	6.5832	1.2432
2015	7	22	13	46	52	0.3	1	0.23	89.2	6.5832	1.3389
2015	7	22	13	56	52	0.3	1	0.25	78.7	6.5832	1.4345
2015	7	22	14	6	52	0.3	1	0.21	77.3	6.5832	1.1858
2015	7	22	14	16	52	0.3	1	0.29	58.8	6.5832	1.4536
2015	7	22	14	26	52	0.3	1	0.19	69.7	6.5832	1.0328
2015	7	22	14	36	52	0.3	1	0.18	83.9	6.5832	1.0711
2015	7	22	14	46	52	0.3	1	0.27	70	6.5832	1.4727
2015	7	22	14	56	52	0.3	1	0.19	88	6.5832	1.1093
2015	7	22	15	6	52	0.3	1	0.2	79.8	6.5832	1.1667
2015	7	22	15	16	52	0.3	1	0.24	51.6	6.5832	1.1093
2015	7	22	15	26	52	0.3	1	0.23	86.7	6.5832	1.3197
2015	7	22	15	36	52	0.3	1	0.17	90	6.5832	0.9946
2015	7	22	15	46	52	0.3	1	0.24	86.1	6.5832	1.4153
2015	7	22	15	56	52	0.3	1	0.2	90.9	6.5832	1.1667
2015	7	22	16	6	52	0.3	1	0.27	87.9	6.5832	1.5875
2015	7	22	16	16	52	0.3	1	0.21	51.3	6.5832	0.9563
2015	7	22	16	26	52	0.3	1	0.24	67.3	6.5832	1.2815
2015	7	22	16	36	52	0.3	1	0.25	75.1	6.5832	1.4345
2015	7	22	16	46	52	0.3	1	0.26	67.7	6.5832	1.3962
2015	7	22	16	56	52	0.3	1	0.15	87.5	6.5832	0.8798
2015	7	22	17	6	52	0.3	1	0.15	97.8	6.5832	0.8416
2015	7	22	17	16	52	0.3	1	0.23	90.8	6.5832	1.358

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	22	17	26	52	0.3	1	0.21	89.1	6.5832	1.205
2015	7	22	17	36	52	0.3	1	0.22	92.5	6.5832	1.3006
2015	7	22	17	46	52	0.3	1	0.21	87.3	6.5832	1.205
2015	7	22	17	56	52	0.3	1	0.21	74.9	6.5832	1.205
2015	7	22	18	6	52	0.3	1	0.15	81.2	6.5832	0.8607
2015	7	22	18	16	52	0.3	1	0.25	79.3	6.5832	1.4153
2015	7	22	18	26	52	0.3	1	0.21	90	6.5832	1.205
2015	7	22	18	36	52	0.3	1	0.23	94.9	6.5832	1.3388
2015	7	22	18	46	52	0.3	1	0.21	76.2	6.5832	1.1667
2015	7	22	18	56	52	0.3	1	0.17	97.7	6.5832	0.9946
2015	7	22	19	6	52	0.3	1	0.19	90	6.5832	1.1093
2015	7	22	19	16	52	0.3	1	0.22	76.8	6.5832	1.2241
2015	7	22	19	26	52	0.3	1	0.23	107.4	6.5832	1.2815
2015	7	22	19	36	52	0.3	1	0.23	94.9	6.5832	1.3388
2015	7	22	19	46	52	0.3	1	0.14	87.3	6.5832	0.8224
2015	7	22	19	56	52	0.3	1	0.21	81.9	6.5832	1.205
2015	7	22	20	6	52	0.3	1	0.18	75.2	6.5832	1.0137
2015	7	22	20	16	52	0.3	1	0.24	88.5	6.5832	1.4154
2015	7	22	20	26	52	0.3	1	0.14	98.3	6.5832	0.7842
2015	7	22	20	36	52	0.3	1	0.14	97.9	6.5832	0.8224
2015	7	22	20	46	52	0.3	1	0.23	97.3	6.5832	1.3389
2015	7	22	20	56	52	0.3	1	0.18	96.2	6.5832	1.052
2015	7	22	21	6	52	0.3	1	0.2	78.7	6.5832	1.1476
2015	7	22	21	16	52	0.3	1	0.22	102.2	6.5832	1.2432
2015	7	22	21	26	52	0.3	1	0.15	79.7	6.5832	0.8416
2015	7	22	21	36	52	0.3	1	0.17	96.7	6.5832	0.9755
2015	7	22	21	46	52	0.3	1	0.2	90.9	6.6026	1.1704
2015	7	22	21	56	52	0.3	1	0.26	97.8	6.5832	1.5301
2015	7	22	22	6	52	0.3	1	0.16	100.6	6.5832	0.9181
2015	7	22	22	16	52	0.3	1	0.24	78.1	6.5832	1.358
2015	7	22	22	26	52	0.3	1	0.27	102.1	6.6026	1.5158
2015	7	22	22	36	52	0.3	1	0.2	90	6.6026	1.1704
2015	7	22	22	46	52	0.3	1	0.23	76.8	6.6026	1.3047
2015	7	22	22	56	52	0.3	1	0.21	98.3	6.6026	1.1896

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	22	23	6	52	0.3	1	0.19	101.9	6.6026	1.0937
2015	7	22	23	16	52	0.3	1	0.19	126.1	6.6026	0.921
2015	7	22	23	26	52	0.3	1	0.2	86.2	6.6026	1.1512
2015	7	22	23	36	52	0.3	1	0.17	94.3	6.6026	1.0169
2015	7	22	23	46	52	0.3	1	0.22	90.9	6.6026	1.2664
2015	7	22	23	56	52	0.3	1	0.21	108.2	6.6026	1.1704
2015	7	23	0	6	52	0.3	1	0.19	98	6.6026	1.0937
2015	7	23	0	16	52	0.3	1	0.16	80.3	6.6026	0.9018
2015	7	23	0	26	52	0.3	1	0.22	92.6	6.6026	1.2664
2015	7	23	0	36	52	0.3	1	0.16	95.8	6.6026	0.9402
2015	7	23	0	46	52	0.3	1	0.2	103.6	6.6026	1.1129
2015	7	23	0	56	52	0.3	1	0.13	115.9	6.6026	0.7099
2015	7	23	1	6	52	0.3	1	0.24	98.7	6.6026	1.3815
2015	7	23	1	16	52	0.3	1	0.2	106.6	6.6026	1.0937
2015	7	23	1	26	52	0.3	1	0.16	108.4	6.6026	0.8634
2015	7	23	1	36	52	0.3	1	0.33	93.4	6.6026	1.9188
2015	7	23	1	46	52	0.3	1	0.27	91.4	6.6026	1.5734
2015	7	23	1	56	52	0.3	1	0.15	124	6.6026	0.7099
2015	7	23	2	6	52	0.3	1	0.19	82	6.6026	1.0937
2015	7	23	2	16	52	0.3	1	0.21	95.3	6.6026	1.2472
2015	7	23	2	26	52	0.3	1	0.26	90	6.6026	1.4966
2015	7	23	2	36	52	0.3	1	0.21	101.8	6.6026	1.1896
2015	7	23	2	46	52	0.3	1	0.15	90	6.6026	0.8634
2015	7	23	2	56	52	0.3	1	0.15	83.5	6.6026	0.8443
2015	7	23	3	6	52	0.3	1	0.15	101.1	6.6026	0.8826
2015	7	23	3	16	52	0.3	1	0.24	97.1	6.6026	1.3815
2015	7	23	3	26	52	0.3	1	0.22	94.3	6.6026	1.2856
2015	7	23	3	36	52	0.3	1	0.2	71.3	6.6026	1.1321
2015	7	23	3	46	52	0.3	1	0.19	100.7	6.6026	1.1129
2015	7	23	3	56	52	0.3	1	0.18	104	6.6219	1.0009
2015	7	23	4	6	52	0.3	1	0.22	95.1	6.6026	1.2856
2015	7	23	4	16	52	0.3	1	0.22	95	6.6026	1.3048
2015	7	23	4	26	52	0.3	1	0.12	90	6.6219	0.7314
2015	7	23	4	36	52	0.3	1	0.1	90	6.6026	0.614

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	23	4	46	52	0.3	1	0.24	76.5	6.6219	1.3666
2015	7	23	4	56	52	0.3	1	0.22	86.6	6.6026	1.3048
2015	7	23	5	6	52	0.3	1	0.14	90	6.6219	0.8277
2015	7	23	5	16	52	0.3	1	0.2	75.1	6.6026	1.1513
2015	7	23	5	26	52	0.3	1	0.22	95	6.6219	1.3089
2015	7	23	5	36	52	0.3	1	0.16	88.8	6.6219	0.9432
2015	7	23	5	46	52	0.3	1	0.19	112.2	6.6219	1.0394
2015	7	23	5	56	52	0.3	1	0.22	94.3	6.6219	1.2896
2015	7	23	6	6	52	0.3	1	0.16	102	6.6219	0.9047
2015	7	23	6	16	52	0.3	1	0.16	97.3	6.6219	0.9047
2015	7	23	6	26	52	0.3	1	0.24	113.1	6.6219	1.3089
2015	7	23	6	36	52	0.3	1	0.2	103.1	6.6219	1.1549
2015	7	23	6	46	52	0.3	1	0.21	119	6.6219	1.0779
2015	7	23	6	56	52	0.3	1	0.2	89.1	6.6219	1.1742
2015	7	23	7	6	52	0.3	1	0.23	106.9	6.6219	1.2704
2015	7	23	7	16	52	0.3	1	0.21	96.1	6.6219	1.2511
2015	7	23	7	26	52	0.3	1	0.12	71.6	6.6026	0.6908
2015	7	23	7	36	52	0.3	1	0.19	108.7	6.6219	1.0779
2015	7	23	7	46	52	0.3	1	0.18	106.8	6.6219	1.0202
2015	7	23	7	56	52	0.3	1	0.13	105.8	6.6219	0.7507
2015	7	23	8	6	52	0.3	1	0.18	80.4	6.6219	1.0202
2015	7	23	8	16	52	0.3	1	0.24	88.4	6.6219	1.3859
2015	7	23	8	26	52	0.3	1	0.19	108.7	6.6219	1.0779
2015	7	23	8	36	52	0.3	1	0.26	91.4	6.6219	1.5399
2015	7	23	8	46	52	0.3	1	0.17	109.5	6.6219	0.9239
2015	7	23	8	56	52	0.3	1	0.13	101.3	6.6219	0.7699
2015	7	23	9	6	52	0.3	1	0.21	90	6.6219	1.2511
2015	7	23	9	16	52	0.3	1	0.12	94.6	6.6219	0.7122
2015	7	23	9	26	52	0.3	1	0.2	75.1	6.6219	1.1549
2015	7	23	9	36	52	0.3	1	0.15	101.1	6.6219	0.8854
2015	7	23	9	46	52	0.3	1	0.22	95.2	6.6219	1.2704
2015	7	23	9	56	52	0.3	1	0.19	75.7	6.6219	1.0586
2015	7	23	10	6	52	0.3	1	0.25	99.7	6.6219	1.4628
2015	7	23	10	16	52	0.3	1	0.23	83.6	6.6219	1.3666

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	23	10	26	52	0.3	1	0.26	81.9	6.6219	1.4821
2015	7	23	10	36	52	0.3	1	0.19	87	6.6219	1.0971
2015	7	23	10	46	52	0.3	1	0.14	104.7	6.6026	0.8059
2015	7	23	10	56	52	0.3	1	0.19	102.1	6.6219	1.0779
2015	7	23	11	6	52	0.3	1	0.17	78.9	6.6026	0.9786
2015	7	23	11	16	52	0.3	1	0.22	95	6.6026	1.3047
2015	7	23	11	26	52	0.3	1	0.23	93.3	6.6026	1.3431
2015	7	23	11	36	52	0.3	1	0.24	91.5	6.6026	1.4199
2015	7	23	11	46	52	0.3	1	0.15	101.1	6.6026	0.8826
2015	7	23	11	56	52	0.3	1	0.18	86.8	6.6026	1.0361
2015	7	23	12	6	52	0.3	1	0.2	80.4	6.5832	1.1285
2015	7	23	12	16	52	0.3	1	0.22	99.6	6.5832	1.2433
2015	7	23	12	26	52	0.3	1	0.26	103.9	6.5832	1.4728
2015	7	23	12	36	52	0.3	1	0.19	84	6.5832	1.0902
2015	7	23	12	46	52	0.3	1	0.23	97.5	6.5832	1.3006
2015	7	23	12	56	52	0.3	1	0.25	90	6.5832	1.4345
2015	7	23	13	6	52	0.3	1	0.19	62.6	6.5832	0.9946
2015	7	23	13	16	52	0.3	1	0.18	98.4	6.5832	1.0328
2015	7	23	13	26	52	0.3	1	0.13	97.3	6.5832	0.7459
2015	7	23	13	36	52	0.3	1	0.21	107.6	6.5639	1.144
2015	7	23	13	46	52	0.3	1	0.2	90	6.5639	1.144
2015	7	23	13	56	52	0.3	1	0.32	78.8	6.5639	1.8303
2015	7	23	14	6	52	0.3	1	0.22	87.5	6.5639	1.2965
2015	7	23	14	16	52	0.3	1	0.07	76.6	6.5639	0.4004
2015	7	23	14	26	52	0.3	1	0.23	89.2	6.5639	1.3346
2015	7	23	14	36	52	0.3	1	0.19	78.3	6.5445	1.1023
2015	7	23	14	46	52	0.3	1	0.16	85.2	6.5445	0.9123
2015	7	23	14	56	52	0.3	1	0.19	72.5	6.5252	1.023
2015	7	23	15	6	52	0.3	1	0.2	75.5	6.5252	1.0988
2015	7	23	15	16	52	0.3	1	0.16	90	6.5252	0.9473
2015	7	23	15	26	52	0.3	1	0.2	63	6.5252	1.042
2015	7	23	15	36	52	0.3	1	0.16	84.3	6.5058	0.9442
2015	7	23	15	46	52	0.3	1	0.13	69.8	6.5058	0.7176
2015	7	23	15	56	52	0.3	1	0.18	82.7	6.5058	1.0387

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	23	16	6	52	0.3	1	0.15	82.2	6.5058	0.8309
2015	7	23	16	16	52	0.3	1	0.17	69	6.5058	0.8876
2015	7	23	16	26	52	0.3	1	0.13	87.2	6.5058	0.7743
2015	7	23	16	36	52	0.3	1	0.23	83.5	6.5058	1.3219
2015	7	23	16	46	52	0.3	1	0.19	79.9	6.4864	1.0542
2015	7	23	16	56	52	0.3	1	0.16	100.8	6.4864	0.8848
2015	7	23	17	6	52	0.3	1	0.17	82.3	6.4864	0.9789
2015	7	23	17	16	52	0.3	1	0.16	83.9	6.4864	0.8848
2015	7	23	17	26	52	0.3	1	0.22	88.3	6.4864	1.2612
2015	7	23	17	36	52	0.3	1	0.13	62.2	6.4864	0.6777
2015	7	23	17	46	52	0.3	1	0.27	81	6.4864	1.5436
2015	7	23	17	56	52	0.3	1	0.15	79.7	6.4864	0.8283
2015	7	23	18	6	52	0.3	1	0.14	65.9	6.4864	0.7153
2015	7	23	18	16	52	0.3	1	0.18	83.9	6.4864	1.0542
2015	7	23	18	26	52	0.3	1	0.23	81.6	6.4671	1.276
2015	7	23	18	36	52	0.3	1	0.15	76.3	6.4864	0.8471
2015	7	23	18	46	52	0.3	1	0.25	90	6.4864	1.4495
2015	7	23	18	56	52	0.3	1	0.2	80.7	6.4864	1.1483
2015	7	23	19	6	52	0.3	1	0.2	80.7	6.4864	1.1483
2015	7	23	19	16	52	0.3	1	0.23	86.7	6.4864	1.2989
2015	7	23	19	26	52	0.3	1	0.22	92.6	6.4671	1.2385
2015	7	23	19	36	52	0.3	1	0.19	85.1	6.4671	1.0883
2015	7	23	19	46	52	0.3	1	0.27	83	6.4864	1.5436
2015	7	23	19	56	52	0.3	1	0.19	90	6.4671	1.1071
2015	7	23	20	6	52	0.3	1	0.17	93.4	6.4864	0.9601
2015	7	23	20	16	52	0.3	1	0.18	93.2	6.4671	1.0133
2015	7	23	20	26	52	0.3	1	0.15	93.7	6.4864	0.8848
2015	7	23	20	36	52	0.3	1	0.19	92	6.4864	1.073
2015	7	23	20	46	52	0.3	1	0.14	106.3	6.4671	0.7693
2015	7	23	20	56	52	0.3	1	0.13	81.3	6.4864	0.7342
2015	7	23	21	6	52	0.3	1	0.22	100.2	6.4864	1.2613
2015	7	23	21	16	52	0.3	1	0.2	82.3	6.4864	1.1107
2015	7	23	21	26	52	0.3	1	0.2	106.3	6.4864	1.0918
2015	7	23	21	36	52	0.3	1	0.13	92.9	6.4671	0.7506

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	23	21	46	52	0.3	1	0.17	64.4	6.4864	0.9036
2015	7	23	21	56	52	0.3	1	0.21	75.5	6.4864	1.1671
2015	7	23	22	6	52	0.3	1	0.18	86.9	6.4864	1.0542
2015	7	23	22	16	52	0.3	1	0.2	93.8	6.4671	1.1259
2015	7	23	22	26	52	0.3	1	0.21	89.1	6.4864	1.2048
2015	7	23	22	36	52	0.3	1	0.18	60.1	6.4671	0.8819
2015	7	23	22	46	52	0.3	1	0.21	106.7	6.4671	1.1259
2015	7	23	22	56	52	0.3	1	0.15	119.9	6.4671	0.7506
2015	7	23	23	6	52	0.3	1	0.13	105.1	6.4671	0.6943
2015	7	23	23	16	52	0.3	1	0.15	83.8	6.4671	0.8632
2015	7	23	23	26	52	0.3	1	0.19	83.1	6.4671	1.0884
2015	7	23	23	36	52	0.3	1	0.14	100.8	6.4671	0.7881
2015	7	23	23	46	52	0.3	1	0.2	77.6	6.4671	1.1071
2015	7	23	23	56	52	0.3	1	0.17	112.2	6.4671	0.9195
2015	7	24	0	6	52	0.3	1	0.11	78.4	6.4671	0.638
2015	7	24	0	16	52	0.3	1	0.18	90	6.4671	1.0133
2015	7	24	0	26	52	0.3	1	0.13	92.8	6.4671	0.7694
2015	7	24	0	36	52	0.3	1	0.16	104	6.4671	0.9007
2015	7	24	0	46	52	0.3	1	0.1	118.2	6.4671	0.5254
2015	7	24	0	56	52	0.3	1	0.11	131.5	6.4671	0.4879
2015	7	24	1	6	52	0.3	1	0.1	133.7	6.4671	0.4316
2015	7	24	1	16	52	0.3	1	0.1	65.1	6.4671	0.5254
2015	7	24	1	26	52	0.3	1	0.12	70	6.4671	0.6193
2015	7	24	1	36	52	0.3	1	0.15	83.7	6.4671	0.8444
2015	7	24	1	46	52	0.3	1	0.23	97.3	6.4671	1.3136
2015	7	24	1	56	52	0.3	1	0.21	93.5	6.4671	1.2198
2015	7	24	2	6	52	0.3	1	0.18	104.8	6.4671	0.9946
2015	7	24	2	16	52	0.3	1	0.17	138.2	6.4671	0.638
2015	7	24	2	26	52	0.3	1	0.23	111.3	6.4671	1.201
2015	7	24	2	36	52	0.3	1	0.19	90	6.4671	1.0884
2015	7	24	2	46	52	0.3	1	0.23	91.6	6.4671	1.3136
2015	7	24	2	56	52	0.3	1	0.17	111	6.4671	0.882
2015	7	24	3	6	52	0.3	1	0.14	108.9	6.4671	0.7694
2015	7	24	3	16	52	0.3	1	0.17	90	6.4671	0.9946

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	24	3	26	52	0.3	1	0.2	108.4	6.4671	1.0696
2015	7	24	3	36	52	0.3	1	0.23	76.2	6.4671	1.2948
2015	7	24	3	46	52	0.3	1	0.2	73.7	6.4671	1.0884
2015	7	24	3	56	52	0.3	1	0.16	104.3	6.4671	0.882
2015	7	24	4	6	52	0.3	1	0.17	83.4	6.4671	0.9758
2015	7	24	4	16	52	0.3	1	0.17	82.2	6.4671	0.9571
2015	7	24	4	26	52	0.3	1	0.11	102.3	6.4671	0.6005
2015	7	24	4	36	52	0.3	1	0.18	90	6.4671	1.0321
2015	7	24	4	46	52	0.3	1	0.13	100.4	6.4671	0.7131
2015	7	24	4	56	52	0.3	1	0.16	92.3	6.4671	0.9383
2015	7	24	5	6	52	0.3	1	0.11	98.9	6.4864	0.6024
2015	7	24	5	16	52	0.3	1	0.21	83.7	6.4864	1.186
2015	7	24	5	26	52	0.3	1	0.12	85.4	6.4864	0.6966
2015	7	24	5	36	52	0.3	1	0.21	111.3	6.4864	1.1107
2015	7	24	5	46	52	0.3	1	0.18	108.4	6.4864	0.9601
2015	7	24	5	56	52	0.3	1	0.22	113.5	6.5058	1.171
2015	7	24	6	6	52	0.3	1	0.24	103.7	6.5058	1.3221
2015	7	24	6	16	52	0.3	1	0.1	97.9	6.5252	0.5495
2015	7	24	6	26	52	0.3	1	0.15	83.8	6.5252	0.8716
2015	7	24	6	36	52	0.3	1	0.2	89.1	6.5252	1.1747
2015	7	24	6	46	52	0.3	1	0.17	108.8	6.5252	0.9473
2015	7	24	6	56	52	0.3	1	0.19	85.1	6.5445	1.1024
2015	7	24	7	6	52	0.3	1	0.12	111.5	6.5445	0.6272
2015	7	24	7	16	52	0.3	1	0.21	95.4	6.5445	1.2165
2015	7	24	7	26	52	0.3	1	0.15	85	6.5639	0.8771
2015	7	24	7	36	52	0.3	1	0.19	90	6.5639	1.0868
2015	7	24	7	46	52	0.3	1	0.2	100.2	6.5639	1.1631
2015	7	24	7	56	52	0.3	1	0.17	96.8	6.5639	0.9534
2015	7	24	8	6	52	0.3	1	0.24	94.8	6.5639	1.3729
2015	7	24	8	16	52	0.3	1	0.15	91.2	6.5639	0.8962
2015	7	24	8	26	52	0.3	1	0.26	90	6.5639	1.4873
2015	7	24	8	36	52	0.3	1	0.19	87.1	6.5639	1.125
2015	7	24	8	46	52	0.3	1	0.28	94.1	6.5639	1.6017
2015	7	24	8	56	52	0.3	1	0.15	88.8	6.5639	0.8962

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	24	9	6	52	0.3	1	0.19	102.1	6.5639	1.0678
2015	7	24	9	16	52	0.3	1	0.18	98.4	6.5639	1.0296
2015	7	24	9	26	52	0.3	1	0.17	82	6.5832	0.9564
2015	7	24	9	36	52	0.3	1	0.17	90	6.5832	1.0138
2015	7	24	9	46	52	0.3	1	0.19	80	6.5832	1.0903
2015	7	24	9	56	52	0.3	1	0.17	100.9	6.5832	0.9946
2015	7	24	10	6	52	0.3	1	0.2	69.4	6.5832	1.0711
2015	7	24	10	16	52	0.3	1	0.19	91	6.5832	1.1285
2015	7	24	10	26	52	0.3	1	0.24	90	6.5832	1.3963
2015	7	24	10	36	52	0.3	1	0.12	86.8	6.5832	0.6886
2015	7	24	10	46	52	0.3	1	0.18	90	6.5832	1.0329
2015	7	24	10	56	52	0.3	1	0.19	65.6	6.5832	1.0137
2015	7	24	11	6	52	0.3	1	0.18	106.1	6.5832	0.9946
2015	7	24	11	16	52	0.3	1	0.23	85.9	6.5832	1.3389
2015	7	24	11	26	52	0.3	1	0.15	75.7	6.5832	0.8225
2015	7	24	11	36	52	0.3	1	0.15	97.8	6.5832	0.8416
2015	7	24	11	46	52	0.3	1	0.22	90	6.5832	1.2815
2015	7	24	11	56	52	0.3	1	0.19	95.8	6.5832	1.1285
2015	7	24	12	6	52	0.3	1	0.2	90	6.5832	1.1859
2015	7	24	12	16	52	0.3	1	0.2	78.7	6.5832	1.1476
2015	7	24	12	26	52	0.3	1	0.17	94.3	6.5832	1.0137
2015	7	24	12	36	52	0.3	1	0.18	72.2	6.5832	1.0137
2015	7	24	12	46	52	0.3	1	0.33	94.6	6.5832	1.9127
2015	7	24	12	56	52	0.3	1	0.17	81.1	6.5832	0.9755
2015	7	24	13	6	52	0.3	1	0.21	67.5	6.5832	1.1094
2015	7	24	13	16	52	0.3	1	0.18	69.9	6.5832	0.9946
2015	7	24	13	26	52	0.3	1	0.17	84.6	6.5832	1.0137
2015	7	24	13	36	52	0.3	1	0.27	86.5	6.5832	1.5684
2015	7	24	13	46	52	0.3	1	0.17	85.6	6.5832	0.9946
2015	7	24	13	56	52	0.3	1	0.22	89.2	6.5832	1.3006
2015	7	24	14	6	52	0.3	1	0.18	61.1	6.5832	0.9372
2015	7	24	14	16	52	0.3	1	0.22	54.2	6.5832	1.0328
2015	7	24	14	26	52	0.3	1	0.2	82.5	6.5832	1.1667
2015	7	24	14	36	52	0.3	1	0.24	71.6	6.5832	1.3197

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	24	14	46	52	0.3	1	0.23	68.2	6.5639	1.2393
2015	7	24	14	56	52	0.3	1	0.17	52.9	6.5832	0.7842
2015	7	24	15	6	52	0.3	1	0.26	51.1	6.5832	1.1858
2015	7	24	15	16	52	0.3	1	0.24	62.7	6.5639	1.2583
2015	7	24	15	26	52	0.3	1	0.26	64.1	6.5832	1.3388
2015	7	24	15	36	52	0.3	1	0.28	56.5	6.5639	1.3537
2015	7	24	15	46	52	0.3	1	0.23	59	6.5832	1.1476
2015	7	24	15	56	52	0.3	1	0.26	52.8	6.5832	1.1858
2015	7	24	16	6	52	0.3	1	0.29	56.8	6.5832	1.4345
2015	7	24	16	16	52	0.3	1	0.26	56.3	6.5832	1.2623
2015	7	24	16	26	52	0.3	1	0.2	65.2	6.5639	1.0295
2015	7	24	16	36	52	0.3	1	0.27	65.6	6.5832	1.4345
2015	7	24	16	46	52	0.3	1	0.16	73.7	6.5832	0.918
2015	7	24	16	56	52	0.3	1	0.17	92.2	6.5832	1.0137
2015	7	24	17	6	52	0.3	1	0.23	66.4	6.5832	1.2241
2015	7	24	17	16	52	0.3	1	0.2	76.9	6.5832	1.1476
2015	7	24	17	26	52	0.3	1	0.22	84	6.5832	1.2814
2015	7	24	17	36	52	0.3	1	0.16	83	6.5832	0.9372
2015	7	24	17	46	52	0.3	1	0.23	76.6	6.5832	1.2814
2015	7	24	17	56	52	0.3	1	0.23	76.2	6.5832	1.3197
2015	7	24	18	6	52	0.3	1	0.16	78.5	6.5832	0.9372
2015	7	24	18	16	52	0.3	1	0.13	92.9	6.5832	0.765
2015	7	24	18	26	52	0.3	1	0.17	92.2	6.5832	1.0137
2015	7	24	18	36	52	0.3	1	0.25	94.6	6.6026	1.439
2015	7	24	18	46	52	0.3	1	0.16	97.1	6.5832	0.918
2015	7	24	18	56	52	0.3	1	0.23	101.3	6.5832	1.3388
2015	7	24	19	6	52	0.3	1	0.17	93.4	6.5832	0.9754
2015	7	24	19	16	52	0.3	1	0.19	82.1	6.6026	1.1128
2015	7	24	19	26	52	0.3	1	0.13	90	6.6026	0.7675
2015	7	24	19	36	52	0.3	1	0.18	81.6	6.6026	1.0361
2015	7	24	19	46	52	0.3	1	0.13	91.5	6.6026	0.7483
2015	7	24	19	56	52	0.3	1	0.27	102.1	6.6026	1.5157
2015	7	24	20	6	52	0.3	1	0.15	86.3	6.6026	0.8826
2015	7	24	20	16	52	0.3	1	0.17	85.6	6.6026	0.9977

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	24	20	26	52	0.3	1	0.21	99.8	6.6026	1.2279
2015	7	24	20	36	52	0.3	1	0.17	85.6	6.6026	0.9977
2015	7	24	20	46	52	0.3	1	0.2	86.2	6.6219	1.1548
2015	7	24	20	56	52	0.3	1	0.22	94.3	6.6219	1.2703
2015	7	24	21	6	52	0.3	1	0.15	109.7	6.6219	0.8084
2015	7	24	21	16	52	0.3	1	0.22	70.2	6.6219	1.2318
2015	7	24	21	26	52	0.3	1	0.2	85.2	6.6219	1.1548
2015	7	24	21	36	52	0.3	1	0.17	111	6.6219	0.9046
2015	7	24	21	46	52	0.3	1	0.2	85.4	6.6219	1.1933
2015	7	24	21	56	52	0.3	1	0.21	100.1	6.6219	1.1933
2015	7	24	22	6	52	0.3	1	0.21	96.2	6.6219	1.2318
2015	7	24	22	16	52	0.3	1	0.16	107.7	6.6219	0.9046
2015	7	24	22	26	52	0.3	1	0.12	96.3	6.6219	0.6929
2015	7	24	22	36	52	0.3	1	0.21	68.7	6.6219	1.1356
2015	7	24	22	46	52	0.3	1	0.23	82.6	6.6219	1.3281
2015	7	24	22	56	52	0.3	1	0.23	99.1	6.6219	1.3281
2015	7	24	23	6	52	0.3	1	0.24	90	6.6219	1.3858
2015	7	24	23	16	52	0.3	1	0.16	109.6	6.6219	0.8661
2015	7	24	23	26	52	0.3	1	0.18	101.3	6.6219	1.0586
2015	7	24	23	36	52	0.3	1	0.06	96	6.6219	0.3657
2015	7	24	23	46	52	0.3	1	0.15	97.4	6.6219	0.8854
2015	7	24	23	56	52	0.3	1	0.29	84.1	6.6219	1.6745
2015	7	25	0	6	52	0.3	1	0.13	82.9	6.6219	0.7699
2015	7	25	0	16	52	0.3	1	0.13	90	6.6219	0.7507
2015	7	25	0	26	52	0.3	1	0.19	107.2	6.6219	1.0586
2015	7	25	0	36	52	0.3	1	0.18	83.9	6.6219	1.0779
2015	7	25	0	46	52	0.3	1	0.21	101.5	6.6219	1.2318
2015	7	25	0	56	52	0.3	1	0.17	95.6	6.6219	0.9816
2015	7	25	1	6	52	0.3	1	0.17	76.8	6.6219	0.9816
2015	7	25	1	16	52	0.3	1	0.18	104.8	6.6219	1.0201
2015	7	25	1	26	52	0.3	1	0.21	86.5	6.6219	1.2511
2015	7	25	1	36	52	0.3	1	0.23	78.4	6.6219	1.3088
2015	7	25	1	46	52	0.3	1	0.2	91.8	6.6219	1.1934
2015	7	25	1	56	52	0.3	1	0.21	107	6.6219	1.1934

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	25	2	6	52	0.3	1	0.16	102.9	6.6219	0.9239
2015	7	25	2	16	52	0.3	1	0.19	95	6.6219	1.0971
2015	7	25	2	26	52	0.3	1	0.17	84.6	6.6219	1.0201
2015	7	25	2	36	52	0.3	1	0.14	92.7	6.6219	0.8277
2015	7	25	2	46	52	0.3	1	0.18	89	6.6219	1.0779
2015	7	25	2	56	52	0.3	1	0.19	84.2	6.6219	1.1356
2015	7	25	3	6	52	0.3	1	0.28	96.1	6.6219	1.6168
2015	7	25	3	16	52	0.3	1	0.18	90	6.6219	1.0586
2015	7	25	3	26	52	0.3	1	0.21	113	6.6219	1.1356
2015	7	25	3	36	52	0.3	1	0.2	94.6	6.6219	1.1934
2015	7	25	3	46	52	0.3	1	0.22	88.3	6.6219	1.3089
2015	7	25	3	56	52	0.3	1	0.18	101.3	6.6219	1.0586
2015	7	25	4	6	52	0.3	1	0.13	103	6.6219	0.7507
2015	7	25	4	16	52	0.3	1	0.2	98.4	6.6219	1.1741
2015	7	25	4	26	52	0.3	1	0.17	85.7	6.6219	1.0202
2015	7	25	4	36	52	0.3	1	0.14	93.9	6.6219	0.8469
2015	7	25	4	46	52	0.3	1	0.25	72.3	6.6219	1.3859
2015	7	25	4	56	52	0.3	1	0.24	85.3	6.6219	1.4051
2015	7	25	5	6	52	0.3	1	0.24	90	6.6219	1.4051
2015	7	25	5	16	52	0.3	1	0.23	82.5	6.6219	1.3089
2015	7	25	5	26	52	0.3	1	0.24	92.3	6.6219	1.4244
2015	7	25	5	36	52	0.3	1	0.16	84.3	6.6219	0.9624
2015	7	25	5	46	52	0.3	1	0.2	101.1	6.6219	1.1741
2015	7	25	5	56	52	0.3	1	0.09	107.7	6.6219	0.4812
2015	7	25	6	6	52	0.3	1	0.17	108.8	6.6219	0.9624
2015	7	25	6	16	52	0.3	1	0.15	120.5	6.6219	0.7507
2015	7	25	6	26	52	0.3	1	0.15	111.1	6.6219	0.8469
2015	7	25	6	36	52	0.3	1	0.14	105.4	6.6219	0.7699
2015	7	25	6	46	52	0.3	1	0.19	108.4	6.6219	1.0394
2015	7	25	6	56	52	0.3	1	0.21	104.7	6.6219	1.1742
2015	7	25	7	6	52	0.3	1	0.19	87	6.6219	1.0972
2015	7	25	7	16	52	0.3	1	0.18	116.6	6.6219	0.9239
2015	7	25	7	26	52	0.3	1	0.12	119.4	6.6219	0.6159
2015	7	25	7	36	52	0.3	1	0.17	109.1	6.6219	0.9432

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	25	7	46	52	0.3	1	0.16	109.9	6.6219	0.9047
2015	7	25	7	56	52	0.3	1	0.3	104.6	6.6219	1.6939
2015	7	25	8	6	52	0.3	1	0.24	77.1	6.6219	1.3474
2015	7	25	8	16	52	0.3	1	0.19	100	6.6219	1.0972
2015	7	25	8	26	52	0.3	1	0.17	100.2	6.6219	0.9624
2015	7	25	8	36	52	0.3	1	0.18	101.7	6.6413	1.0234
2015	7	25	8	46	52	0.3	1	0.23	100.7	6.6219	1.3281
2015	7	25	8	56	52	0.3	1	0.22	90.9	6.6219	1.2704
2015	7	25	9	6	52	0.3	1	0.22	84.8	6.6413	1.2744
2015	7	25	9	16	52	0.3	1	0.18	80.7	6.6219	1.0587
2015	7	25	9	26	52	0.3	1	0.21	99.2	6.6413	1.1971
2015	7	25	9	36	52	0.3	1	0.19	93	6.6413	1.1006
2015	7	25	9	46	52	0.3	1	0.21	104.7	6.6413	1.1778
2015	7	25	9	56	52	0.3	1	0.15	74.4	6.6219	0.8277
2015	7	25	10	6	52	0.3	1	0.25	81.8	6.6219	1.4629
2015	7	25	10	16	52	0.3	1	0.18	86.8	6.6219	1.0394
2015	7	25	10	26	52	0.3	1	0.22	78.9	6.6413	1.2744
2015	7	25	10	36	52	0.3	1	0.21	72.1	6.6219	1.1934
2015	7	25	10	46	52	0.3	1	0.23	75.4	6.6219	1.3281
2015	7	25	10	56	52	0.3	1	0.17	81.1	6.6219	0.9816
2015	7	25	11	6	52	0.3	1	0.2	95.7	6.6219	1.1549
2015	7	25	11	16	52	0.3	1	0.21	85.6	6.6219	1.2511
2015	7	25	11	26	52	0.3	1	0.21	73	6.6219	1.1934
2015	7	25	11	36	52	0.3	1	0.22	60	6.6219	1.1356
2015	7	25	11	46	52	0.3	1	0.18	85.8	6.6219	1.0586
2015	7	25	11	56	52	0.3	1	0.21	83.9	6.6219	1.2511
2015	7	25	12	6	52	0.3	1	0.18	62.5	6.6026	0.9594
2015	7	25	12	16	52	0.3	1	0.2	80.7	6.6026	1.1704
2015	7	25	12	26	52	0.3	1	0.23	82.5	6.6026	1.3048
2015	7	25	12	36	52	0.3	1	0.23	80	6.6026	1.3047
2015	7	25	12	46	52	0.3	1	0.24	51.2	6.6026	1.0745
2015	7	25	12	56	52	0.3	1	0.2	79.8	6.6026	1.1704
2015	7	25	13	6	52	0.3	1	0.23	73.1	6.6026	1.2664
2015	7	25	13	16	52	0.3	1	0.26	75.6	6.6026	1.4966

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	25	13	26	52	0.3	1	0.25	78	6.6026	1.439
2015	7	25	13	36	52	0.3	1	0.2	76.4	6.6026	1.1128
2015	7	25	13	46	52	0.3	1	0.19	60.8	6.6026	0.9593
2015	7	25	13	56	52	0.3	1	0.19	76.2	6.6026	1.0937
2015	7	25	14	6	52	0.3	1	0.15	96.2	6.6026	0.8826
2015	7	25	14	16	52	0.3	1	0.25	65.4	6.5832	1.3389
2015	7	25	14	26	52	0.3	1	0.21	85.5	6.6026	1.228
2015	7	25	14	36	52	0.3	1	0.2	73.4	6.6026	1.0936
2015	7	25	14	46	52	0.3	1	0.22	69.4	6.6026	1.2279
2015	7	25	14	56	52	0.3	1	0.2	66.4	6.5832	1.0519
2015	7	25	15	6	52	0.3	1	0.17	79.8	6.5832	0.9563
2015	7	25	15	16	52	0.3	1	0.2	75.1	6.5832	1.1476
2015	7	25	15	26	52	0.3	1	0.24	59.3	6.5832	1.2241
2015	7	25	15	36	52	0.3	1	0.21	74.4	6.5832	1.1667
2015	7	25	15	46	52	0.3	1	0.22	75.6	6.5832	1.2623
2015	7	25	15	56	52	0.3	1	0.18	85.8	6.5832	1.0519
2015	7	25	16	6	52	0.3	1	0.17	90	6.5832	1.0137
2015	7	25	16	16	52	0.3	1	0.14	92.7	6.5639	0.8198
2015	7	25	16	26	52	0.3	1	0.18	91.1	6.5639	1.0296
2015	7	25	16	36	52	0.3	1	0.18	90	6.5832	1.0519
2015	7	25	16	46	52	0.3	1	0.2	68.4	6.5832	1.1093
2015	7	25	16	56	52	0.3	1	0.22	79.7	6.5832	1.2623
2015	7	25	17	6	52	0.3	1	0.18	65.8	6.5639	0.9342
2015	7	25	17	16	52	0.3	1	0.15	88.8	6.5639	0.8961
2015	7	25	17	26	52	0.3	1	0.28	73.2	6.5832	1.5875
2015	7	25	17	36	52	0.3	1	0.22	60.4	6.5639	1.1058
2015	7	25	17	46	52	0.3	1	0.16	83	6.5639	0.9342
2015	7	25	17	56	52	0.3	1	0.18	99.3	6.5832	1.0519
2015	7	25	18	6	52	0.3	1	0.17	91.1	6.5832	0.9946
2015	7	25	18	16	52	0.3	1	0.26	73.7	6.5832	1.4345
2015	7	25	18	26	52	0.3	1	0.16	112.2	6.5832	0.8416
2015	7	25	18	36	52	0.3	1	0.17	90	6.5832	0.9946
2015	7	25	18	46	52	0.3	1	0.14	78.2	6.5832	0.8224
2015	7	25	18	56	52	0.3	1	0.15	98.8	6.5832	0.8607

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	25	19	6	52	0.3	1	0.14	90	6.5832	0.8224
2015	7	25	19	16	52	0.3	1	0.24	90	6.5832	1.4153
2015	7	25	19	26	52	0.3	1	0.23	98.1	6.5832	1.3388
2015	7	25	19	36	52	0.3	1	0.18	84.9	6.5832	1.0711
2015	7	25	19	46	52	0.3	1	0.17	117.6	6.5832	0.8798
2015	7	25	19	56	52	0.3	1	0.2	95.5	6.5832	1.1858
2015	7	25	20	6	52	0.3	1	0.21	112.1	6.5832	1.1284
2015	7	25	20	16	52	0.3	1	0.16	84.3	6.5832	0.9563
2015	7	25	20	26	52	0.3	1	0.19	86.1	6.5639	1.1058
2015	7	25	20	36	52	0.3	1	0.21	114.6	6.5832	1.1285
2015	7	25	20	46	52	0.3	1	0.16	124.3	6.5832	0.7842
2015	7	25	20	56	52	0.3	1	0.17	101.1	6.5832	0.9754
2015	7	25	21	6	52	0.3	1	0.2	97.7	6.5832	1.1285
2015	7	25	21	16	52	0.3	1	0.22	95.1	6.5832	1.2815
2015	7	25	21	26	52	0.3	1	0.18	110.1	6.5832	0.9946
2015	7	25	21	36	52	0.3	1	0.22	90	6.6026	1.2663
2015	7	25	21	46	52	0.3	1	0.22	76.8	6.6026	1.228
2015	7	25	21	56	52	0.3	1	0.15	90	6.5832	0.8798
2015	7	25	22	6	52	0.3	1	0.17	86.6	6.5832	0.9755
2015	7	25	22	16	52	0.3	1	0.21	74.9	6.6026	1.2088
2015	7	25	22	26	52	0.3	1	0.17	98.9	6.5832	0.9755
2015	7	25	22	36	52	0.3	1	0.25	94.6	6.6026	1.439
2015	7	25	22	46	52	0.3	1	0.21	96.1	6.5832	1.2432
2015	7	25	22	56	52	0.3	1	0.2	109.7	6.6026	1.0745
2015	7	25	23	6	52	0.3	1	0.23	86.7	6.6026	1.3431
2015	7	25	23	16	52	0.3	1	0.24	103.5	6.5832	1.358
2015	7	25	23	26	52	0.3	1	0.2	95.5	6.6026	1.1896
2015	7	25	23	36	52	0.3	1	0.16	95.8	6.6026	0.9402
2015	7	25	23	46	52	0.3	1	0.19	99	6.6026	1.0937
2015	7	25	23	56	52	0.3	1	0.21	77.5	6.6026	1.2088
2015	7	26	0	6	52	0.3	1	0.21	64.7	6.6026	1.0937
2015	7	26	0	16	52	0.3	1	0.2	99.6	6.5832	1.1285
2015	7	26	0	26	52	0.3	1	0.16	90	6.6026	0.9402
2015	7	26	0	36	52	0.3	1	0.2	86.3	6.6026	1.1896

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	26	0	46	52	0.3	1	0.17	97.8	6.6026	0.9786
2015	7	26	0	56	52	0.3	1	0.2	91.9	6.6026	1.1512
2015	7	26	1	6	52	0.3	1	0.26	102.4	6.6026	1.4774
2015	7	26	1	16	52	0.3	1	0.2	122.9	6.6026	0.9786
2015	7	26	1	26	52	0.3	1	0.22	87.4	6.6026	1.2664
2015	7	26	1	36	52	0.3	1	0.16	99.3	6.6026	0.9402
2015	7	26	1	46	52	0.3	1	0.17	114.5	6.6026	0.8826
2015	7	26	1	56	52	0.3	1	0.16	108.4	6.6026	0.8634
2015	7	26	2	6	52	0.3	1	0.18	100.5	6.5832	1.0329
2015	7	26	2	16	52	0.3	1	0.13	90	6.6026	0.7867
2015	7	26	2	26	52	0.3	1	0.15	101.1	6.6026	0.8826
2015	7	26	2	36	52	0.3	1	0.21	64.7	6.6026	1.0937
2015	7	26	2	46	52	0.3	1	0.17	90	6.6026	1.0169
2015	7	26	2	56	52	0.3	1	0.22	90	6.6026	1.2856
2015	7	26	3	6	52	0.3	1	0.16	81.7	6.6026	0.921
2015	7	26	3	16	52	0.3	1	0.16	90	6.6026	0.9594
2015	7	26	3	26	52	0.3	1	0.17	92.2	6.6026	0.9786
2015	7	26	3	36	52	0.3	1	0.27	103.5	6.6026	1.5158
2015	7	26	3	46	52	0.3	1	0.11	90	6.6026	0.6332
2015	7	26	3	56	52	0.3	1	0.18	94.2	6.6026	1.0553
2015	7	26	4	6	52	0.3	1	0.2	89.1	6.6026	1.1897
2015	7	26	4	16	52	0.3	1	0.24	94.7	6.6026	1.4007
2015	7	26	4	26	52	0.3	1	0.2	96.5	6.6026	1.1705
2015	7	26	4	36	52	0.3	1	0.14	90	6.6026	0.8251
2015	7	26	4	46	52	0.3	1	0.2	107.5	6.6026	1.0937
2015	7	26	4	56	52	0.3	1	0.2	110.6	6.6026	1.0745
2015	7	26	5	6	52	0.3	1	0.23	104.6	6.6026	1.324
2015	7	26	5	16	52	0.3	1	0.19	78.3	6.6026	1.1129
2015	7	26	5	26	52	0.3	1	0.16	80.7	6.6026	0.9402
2015	7	26	5	36	52	0.3	1	0.21	111.8	6.6026	1.1513
2015	7	26	5	46	52	0.3	1	0.22	97.7	6.6026	1.2856
2015	7	26	5	56	52	0.3	1	0.16	88.8	6.6026	0.9402
2015	7	26	6	6	52	0.3	1	0.16	90	6.6026	0.921
2015	7	26	6	16	52	0.3	1	0.18	100.5	6.6026	1.0362

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	26	6	26	52	0.3	1	0.2	109.3	6.6026	1.0937
2015	7	26	6	36	52	0.3	1	0.15	96.3	6.6026	0.8635
2015	7	26	6	46	52	0.3	1	0.24	102.9	6.6026	1.3432
2015	7	26	6	56	52	0.3	1	0.21	102.5	6.6026	1.2089
2015	7	26	7	6	52	0.3	1	0.18	100.3	6.6026	1.0554
2015	7	26	7	16	52	0.3	1	0.24	111.7	6.6026	1.3048
2015	7	26	7	26	52	0.3	1	0.21	109	6.6026	1.1705
2015	7	26	7	36	52	0.3	1	0.15	106.1	6.6026	0.8635
2015	7	26	7	46	52	0.3	1	0.14	88.6	6.6026	0.8059
2015	7	26	7	56	52	0.3	1	0.15	97.4	6.6026	0.8827
2015	7	26	8	6	52	0.3	1	0.12	64.1	6.6026	0.6332
2015	7	26	8	16	52	0.3	1	0.22	85.7	6.6026	1.2856
2015	7	26	8	26	52	0.3	1	0.14	87.4	6.6026	0.8443
2015	7	26	8	36	52	0.3	1	0.21	71.8	6.6219	1.1742
2015	7	26	8	46	52	0.3	1	0.15	88.8	6.6219	0.9047
2015	7	26	8	56	52	0.3	1	0.18	73.5	6.6219	1.0394
2015	7	26	9	6	52	0.3	1	0.07	81.5	6.6219	0.385
2015	7	26	9	16	52	0.3	1	0.12	90	6.6219	0.7314
2015	7	26	9	26	52	0.3	1	0.22	75.6	6.6026	1.2664
2015	7	26	9	36	52	0.3	1	0.17	86.7	6.6219	1.0009
2015	7	26	9	46	52	0.3	1	0.08	119.7	6.6219	0.4042
2015	7	26	9	56	52	0.3	1	0.2	106.1	6.6026	1.1321
2015	7	26	10	6	52	0.3	1	0.18	99.6	6.6219	1.0202
2015	7	26	10	16	52	0.3	1	0.18	84.9	6.6026	1.0745
2015	7	26	10	26	52	0.3	1	0.22	87.4	6.6026	1.2664
2015	7	26	10	36	52	0.3	1	0.16	76	6.6026	0.921
2015	7	26	10	46	52	0.3	1	0.13	92.8	6.6026	0.7867
2015	7	26	10	56	52	0.3	1	0.19	76.9	6.6026	1.0745
2015	7	26	11	6	52	0.3	1	0.2	75.1	6.6026	1.1513
2015	7	26	11	16	52	0.3	1	0.21	69.6	6.6026	1.1321
2015	7	26	11	26	52	0.3	1	0.21	70.7	6.6026	1.1513
2015	7	26	11	36	52	0.3	1	0.22	85.7	6.6026	1.2856
2015	7	26	11	46	52	0.3	1	0.22	68.8	6.6026	1.1896
2015	7	26	11	56	52	0.3	1	0.23	81.6	6.6026	1.3048

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	26	12	6	52	0.3	1	0.2	100.6	6.6026	1.1321
2015	7	26	12	16	52	0.3	1	0.19	74.3	6.5832	1.0903
2015	7	26	12	26	52	0.3	1	0.23	60.5	6.6026	1.1513
2015	7	26	12	36	52	0.3	1	0.16	76	6.5832	0.9181
2015	7	26	12	46	52	0.3	1	0.21	75.7	6.5832	1.205
2015	7	26	12	56	52	0.3	1	0.21	74.9	6.5832	1.205
2015	7	26	13	6	52	0.3	1	0.15	90	6.5832	0.8607
2015	7	26	13	16	52	0.3	1	0.21	71.8	6.5832	1.1667
2015	7	26	13	26	52	0.3	1	0.17	78.9	6.5832	0.9755
2015	7	26	13	36	52	0.3	1	0.17	86.7	6.6026	0.9977
2015	7	26	13	46	52	0.3	1	0.18	89	6.5832	1.0711
2015	7	26	13	56	52	0.3	1	0.16	80.7	6.5832	0.9372
2015	7	26	14	6	52	0.3	1	0.18	81.6	6.5832	1.0328
2015	7	26	14	16	52	0.3	1	0.17	69.8	6.5832	0.9372
2015	7	26	14	26	52	0.3	1	0.26	81.9	6.5832	1.4727
2015	7	26	14	36	52	0.3	1	0.14	79.2	6.5832	0.8033
2015	7	26	14	46	52	0.3	1	0.22	61.1	6.5832	1.1093
2015	7	26	14	56	52	0.3	1	0.21	73	6.5832	1.1858
2015	7	26	15	6	52	0.3	1	0.27	75.1	6.5832	1.511
2015	7	26	15	16	52	0.3	1	0.24	62	6.5832	1.2241
2015	7	26	15	26	52	0.3	1	0.21	75.5	6.5832	1.1858
2015	7	26	15	36	52	0.3	1	0.13	72.9	6.5639	0.7436
2015	7	26	15	46	52	0.3	1	0.21	72.4	6.5639	1.144
2015	7	26	15	56	52	0.3	1	0.26	79.1	6.5832	1.4919
2015	7	26	16	6	52	0.3	1	0.19	78.3	6.5639	1.1058
2015	7	26	16	16	52	0.3	1	0.22	77.8	6.5639	1.2393
2015	7	26	16	26	52	0.3	1	0.18	77.5	6.5639	1.0296
2015	7	26	16	36	52	0.3	1	0.17	63.4	6.5639	0.877
2015	7	26	16	46	52	0.3	1	0.22	77.8	6.5832	1.2432
2015	7	26	16	56	52	0.3	1	0.23	74.6	6.5639	1.3156
2015	7	26	17	6	52	0.3	1	0.16	80.7	6.5639	0.9342
2015	7	26	17	16	52	0.3	1	0.22	80.7	6.5639	1.2774
2015	7	26	17	26	52	0.3	1	0.16	73.7	6.5639	0.9152
2015	7	26	17	36	52	0.3	1	0.17	96.5	6.5639	1.0105

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	26	17	46	52	0.3	1	0.17	92.2	6.5639	1.0105
2015	7	26	17	56	52	0.3	1	0.23	91.6	6.5639	1.3346
2015	7	26	18	6	52	0.3	1	0.16	104.6	6.5639	0.877
2015	7	26	18	16	52	0.3	1	0.18	69	6.5639	0.9914
2015	7	26	18	26	52	0.3	1	0.15	85	6.5639	0.877
2015	7	26	18	36	52	0.3	1	0.11	91.6	6.5639	0.6673
2015	7	26	18	46	52	0.3	1	0.21	98.9	6.5639	1.2202
2015	7	26	18	56	52	0.3	1	0.19	67.1	6.5639	0.9914
2015	7	26	19	6	52	0.3	1	0.2	103.6	6.5639	1.1058
2015	7	26	19	16	52	0.3	1	0.19	107.5	6.5639	1.0296
2015	7	26	19	26	52	0.3	1	0.23	101.3	6.5639	1.3346
2015	7	26	19	36	52	0.3	1	0.17	82	6.5639	0.9533
2015	7	26	19	46	52	0.3	1	0.25	90	6.5832	1.4536
2015	7	26	19	56	52	0.3	1	0.21	126	6.5832	0.9754
2015	7	26	20	6	52	0.3	1	0.17	82	6.5832	0.9563
2015	7	26	20	16	52	0.3	1	0.22	91.7	6.5832	1.2815
2015	7	26	20	26	52	0.3	1	0.17	71.6	6.5832	0.9181
2015	7	26	20	36	52	0.3	1	0.19	91	6.5832	1.1093
2015	7	26	20	46	52	0.3	1	0.15	90	6.5832	0.8798
2015	7	26	20	56	52	0.3	1	0.17	102.4	6.5832	0.9563
2015	7	26	21	6	52	0.3	1	0.13	94.4	6.5832	0.7459
2015	7	26	21	16	52	0.3	1	0.2	101.1	6.5832	1.1667
2015	7	26	21	26	52	0.3	1	0.2	94.7	6.5832	1.1667
2015	7	26	21	36	52	0.3	1	0.2	103.1	6.5832	1.1476
2015	7	26	21	46	52	0.3	1	0.17	98.7	6.5832	0.9946
2015	7	26	21	56	52	0.3	1	0.11	109	6.5832	0.6121
2015	7	26	22	6	52	0.3	1	0.16	91.2	6.6026	0.9402
2015	7	26	22	16	52	0.3	1	0.16	102.9	6.5832	0.9181
2015	7	26	22	26	52	0.3	1	0.17	82.2	6.6026	0.9785
2015	7	26	22	36	52	0.3	1	0.16	87.7	6.5832	0.9563
2015	7	26	22	46	52	0.3	1	0.19	79.1	6.5832	1.0902
2015	7	26	22	56	52	0.3	1	0.22	110.1	6.5832	1.205
2015	7	26	23	6	52	0.3	1	0.21	105.6	6.5832	1.1667
2015	7	26	23	16	52	0.3	1	0.21	116.6	6.5832	1.1094

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	26	23	26	52	0.3	1	0.21	107.9	6.5832	1.1859
2015	7	26	23	36	52	0.3	1	0.24	101.6	6.5832	1.3963
2015	7	26	23	46	52	0.3	1	0.21	109.8	6.5832	1.1667
2015	7	26	23	56	52	0.3	1	0.2	106.1	6.5832	1.1285
2015	7	27	0	6	52	0.3	1	0.18	110.8	6.5832	0.9564
2015	7	27	0	16	52	0.3	1	0.18	112.8	6.5832	0.9564
2015	7	27	0	26	52	0.3	1	0.24	95.4	6.5832	1.4154
2015	7	27	0	36	52	0.3	1	0.17	86.6	6.5832	0.9755
2015	7	27	0	46	52	0.3	1	0.19	104.7	6.5832	1.0903
2015	7	27	0	56	52	0.3	1	0.25	99.2	6.5832	1.4154
2015	7	27	1	6	52	0.3	1	0.22	89.1	6.5832	1.2624
2015	7	27	1	16	52	0.3	1	0.14	65.9	6.5832	0.7268
2015	7	27	1	26	52	0.3	1	0.17	113.6	6.5832	0.9181
2015	7	27	1	36	52	0.3	1	0.17	84.5	6.5832	0.9946
2015	7	27	1	46	52	0.3	1	0.18	125.4	6.5832	0.8607
2015	7	27	1	56	52	0.3	1	0.24	98	6.5832	1.358
2015	7	27	2	6	52	0.3	1	0.23	76.6	6.5832	1.2815
2015	7	27	2	16	52	0.3	1	0.16	97.3	6.5832	0.899
2015	7	27	2	26	52	0.3	1	0.14	96.8	6.5832	0.8034
2015	7	27	2	36	52	0.3	1	0.15	97.8	6.5832	0.8416
2015	7	27	2	46	52	0.3	1	0.18	67.6	6.5832	0.9755
2015	7	27	2	56	52	0.3	1	0.2	104.3	6.5832	1.1285
2015	7	27	3	6	52	0.3	1	0.22	100.3	6.5832	1.2624
2015	7	27	3	16	52	0.3	1	0.23	100.7	6.5832	1.3198
2015	7	27	3	26	52	0.3	1	0.16	104.6	6.5832	0.8799
2015	7	27	3	36	52	0.3	1	0.18	104	6.5832	0.9946
2015	7	27	3	46	52	0.3	1	0.23	90	6.5832	1.3389
2015	7	27	3	56	52	0.3	1	0.16	71.6	6.5832	0.8607
2015	7	27	4	6	52	0.3	1	0.15	102.8	6.5832	0.8416
2015	7	27	4	16	52	0.3	1	0.2	90	6.5832	1.1668
2015	7	27	4	26	52	0.3	1	0.19	63.9	6.5832	1.0138
2015	7	27	4	36	52	0.3	1	0.18	94.2	6.5832	1.052
2015	7	27	4	46	52	0.3	1	0.23	100.7	6.5832	1.3198
2015	7	27	4	56	52	0.3	1	0.19	95.9	6.5832	1.1094

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	27	5	6	52	0.3	1	0.19	102.1	6.5832	1.0712
2015	7	27	5	16	52	0.3	1	0.16	84.3	6.5832	0.9564
2015	7	27	5	26	52	0.3	1	0.18	100.3	6.5832	1.052
2015	7	27	5	36	52	0.3	1	0.25	115.9	6.5832	1.3007
2015	7	27	5	46	52	0.3	1	0.24	104	6.5832	1.3772
2015	7	27	5	56	52	0.3	1	0.28	100.7	6.5832	1.6259
2015	7	27	6	6	52	0.3	1	0.17	114.5	6.5832	0.8799
2015	7	27	6	16	52	0.3	1	0.18	91.1	6.5832	1.0329
2015	7	27	6	26	52	0.3	1	0.19	113.9	6.5832	0.9947
2015	7	27	6	36	52	0.3	1	0.15	104	6.5639	0.839
2015	7	27	6	46	52	0.3	1	0.23	99.1	6.5832	1.3198
2015	7	27	6	56	52	0.3	1	0.18	81.6	6.5832	1.0329
2015	7	27	7	6	52	0.3	1	0.12	110.4	6.5832	0.6695
2015	7	27	7	16	52	0.3	1	0.18	107.4	6.5639	0.9725
2015	7	27	7	26	52	0.3	1	0.17	109.1	6.5639	0.9343
2015	7	27	7	36	52	0.3	1	0.23	80.3	6.5832	1.339
2015	7	27	7	46	52	0.3	1	0.26	73.7	6.5832	1.4346
2015	7	27	7	56	52	0.3	1	0.15	90	6.5832	0.8608
2015	7	27	8	6	52	0.3	1	0.2	81.6	6.5832	1.1668
2015	7	27	8	16	52	0.3	1	0.12	73	6.5639	0.6864
2015	7	27	8	26	52	0.3	1	0.16	93.4	6.5832	0.9564
2015	7	27	8	36	52	0.3	1	0.21	99.2	6.5832	1.1859
2015	7	27	8	46	52	0.3	1	0.23	72.1	6.5639	1.2966
2015	7	27	8	56	52	0.3	1	0.22	80.7	6.5639	1.2775
2015	7	27	9	6	52	0.3	1	0.14	91.3	6.5639	0.8199
2015	7	27	9	16	52	0.3	1	0.1	70.3	6.5639	0.5339
2015	7	27	9	26	52	0.3	1	0.14	67.7	6.5639	0.7436
2015	7	27	9	36	52	0.3	1	0.28	112.7	6.5639	1.5064
2015	7	27	9	46	52	0.3	1	0.16	105.5	6.5639	0.8962
2015	7	27	9	56	52	0.3	1	0.23	77.4	6.5832	1.2816
2015	7	27	10	6	52	0.3	1	0.17	62.4	6.5639	0.8771
2015	7	27	10	16	52	0.3	1	0.24	82	6.5639	1.3538
2015	7	27	10	26	52	0.3	1	0.2	76.4	6.5639	1.1059
2015	7	27	10	36	52	0.3	1	0.17	87.8	6.5639	1.0106

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	27	10	46	52	0.3	1	0.15	78.4	6.5639	0.839
2015	7	27	10	56	52	0.3	1	0.21	91.8	6.5639	1.2013
2015	7	27	11	6	52	0.3	1	0.19	81.2	6.5639	1.1059
2015	7	27	11	16	52	0.3	1	0.21	80.8	6.5639	1.1822
2015	7	27	11	26	52	0.3	1	0.14	72	6.5639	0.7627
2015	7	27	11	36	52	0.3	1	0.09	53.5	6.5639	0.4386
2015	7	27	11	46	52	0.3	1	0.15	66.2	6.5639	0.8199
2015	7	27	11	56	52	0.3	1	0.17	78.9	6.5445	0.9694
2015	7	27	12	6	52	0.3	1	0.18	63.4	6.5445	0.9124
2015	7	27	12	16	52	0.3	1	0.2	87.2	6.5445	1.1594
2015	7	27	12	26	52	0.3	1	0.16	87.7	6.5445	0.9504
2015	7	27	12	36	52	0.3	1	0.17	70.9	6.5445	0.9314
2015	7	27	12	46	52	0.3	1	0.21	55.8	6.5445	1.0074
2015	7	27	12	56	52	0.3	1	0.13	69.8	6.5252	0.72
2015	7	27	13	6	52	0.3	1	0.2	63	6.5252	1.0421
2015	7	27	13	16	52	0.3	1	0.14	88.7	6.5252	0.8336
2015	7	27	13	26	52	0.3	1	0.18	51.7	6.5252	0.8147
2015	7	27	13	36	52	0.3	1	0.12	62	6.5058	0.6043
2015	7	27	13	46	52	0.3	1	0.22	73.7	6.5058	1.2276
2015	7	27	13	56	52	0.3	1	0.15	69.6	6.5058	0.8121
2015	7	27	14	6	52	0.3	1	0.16	69.3	6.5058	0.8499
2015	7	27	14	16	52	0.3	1	0.11	78.4	6.4864	0.6401
2015	7	27	14	26	52	0.3	1	0.1	65.1	6.5058	0.5288
2015	7	27	14	36	52	0.3	1	0.11	56.8	6.4864	0.5459
2015	7	27	14	46	52	0.3	1	0.18	101.7	6.4864	0.9977
2015	7	27	14	56	52	0.3	1	0.19	59.5	6.4864	0.9601
2015	7	27	15	6	52	0.3	1	0.12	87	6.4864	0.7154
2015	7	27	15	16	52	0.3	1	0.15	78.7	6.4864	0.8471
2015	7	27	15	26	52	0.3	1	0.16	68.2	6.4864	0.8471
2015	7	27	15	36	52	0.3	1	0.14	56.7	6.4864	0.6589
2015	7	27	15	46	52	0.3	1	0.15	68	6.4671	0.7881
2015	7	27	15	56	52	0.3	1	0.17	77.6	6.4671	0.9382
2015	7	27	16	6	52	0.3	1	0.18	71.6	6.4671	0.957
2015	7	27	16	16	52	0.3	1	0.19	72.2	6.4671	1.0508

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	27	16	26	52	0.3	1	0.2	68	6.4671	1.0696
2015	7	27	16	36	52	0.3	1	0.18	84.7	6.4671	1.0133
2015	7	27	16	46	52	0.3	1	0.18	91	6.4671	1.0508
2015	7	27	16	56	52	0.3	1	0.22	81.4	6.4671	1.2385
2015	7	27	17	6	52	0.3	1	0.15	86.3	6.4671	0.8819
2015	7	27	17	16	52	0.3	1	0.27	79.6	6.4671	1.5387
2015	7	27	17	26	52	0.3	1	0.16	102.9	6.4671	0.9007
2015	7	27	17	36	52	0.3	1	0.25	77.2	6.4671	1.4074
2015	7	27	17	46	52	0.3	1	0.19	59.5	6.4671	0.957
2015	7	27	17	56	52	0.3	1	0.08	65.6	6.4671	0.4128
2015	7	27	18	6	52	0.3	1	0.17	127.3	6.4671	0.7881
2015	7	27	18	16	52	0.3	1	0.22	106.3	6.4671	1.2197
2015	7	27	18	26	52	0.3	1	0.23	77.7	6.4671	1.2948
2015	7	27	18	36	52	0.3	1	0.19	88	6.4671	1.0696
2015	7	27	18	46	52	0.3	1	0.18	109.1	6.4671	0.9758
2015	7	27	18	56	52	0.3	1	0.17	95.5	6.4671	0.9758
2015	7	27	19	6	52	0.3	1	0.2	113.7	6.4671	1.0696
2015	7	27	19	16	52	0.3	1	0.16	99.3	6.4671	0.9195
2015	7	27	19	26	52	0.3	1	0.16	109.6	6.4864	0.8471
2015	7	27	19	36	52	0.3	1	0.12	109.4	6.4864	0.6401
2015	7	27	19	46	52	0.3	1	0.19	90	6.4864	1.0919
2015	7	27	19	56	52	0.3	1	0.23	94.8	6.4864	1.3366
2015	7	27	20	6	52	0.3	1	0.25	98.5	6.4864	1.3931
2015	7	27	20	16	52	0.3	1	0.23	86.7	6.4864	1.2989
2015	7	27	20	26	52	0.3	1	0.12	91.5	6.4671	0.6943
2015	7	27	20	36	52	0.3	1	0.18	80.7	6.4671	1.0321
2015	7	27	20	46	52	0.3	1	0.23	90.8	6.4671	1.3323
2015	7	27	20	56	52	0.3	1	0.15	104.3	6.4671	0.8069
2015	7	27	21	6	52	0.3	1	0.16	106.3	6.4671	0.9007
2015	7	27	21	16	52	0.3	1	0.2	96.4	6.4671	1.1634
2015	7	27	21	26	52	0.3	1	0.17	113.1	6.4671	0.882
2015	7	27	21	36	52	0.3	1	0.19	101.9	6.4671	1.0696
2015	7	27	21	46	52	0.3	1	0.17	86.6	6.4671	0.957
2015	7	27	21	56	52	0.3	1	0.15	88.8	6.4671	0.8632

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	27	22	6	52	0.3	1	0.2	81.5	6.4671	1.1259
2015	7	27	22	16	52	0.3	1	0.19	86	6.4671	1.0696
2015	7	27	22	26	52	0.3	1	0.18	108.1	6.4671	0.9758
2015	7	27	22	36	52	0.3	1	0.24	90	6.4671	1.3886
2015	7	27	22	46	52	0.3	1	0.17	111.6	6.4671	0.9007
2015	7	27	22	56	52	0.3	1	0.14	92.7	6.4671	0.8069
2015	7	27	23	6	52	0.3	1	0.18	113.3	6.4671	0.957
2015	7	27	23	16	52	0.3	1	0.14	113	6.4671	0.7506
2015	7	27	23	26	52	0.3	1	0.14	102.4	6.4671	0.7694
2015	7	27	23	36	52	0.3	1	0.15	98.7	6.4671	0.8632
2015	7	27	23	46	52	0.3	1	0.25	93.8	6.4671	1.4262
2015	7	27	23	56	52	0.3	1	0.13	105.8	6.4477	0.7295
2015	7	28	0	6	52	0.3	1	0.13	117.2	6.4671	0.6568
2015	7	28	0	16	52	0.3	1	0.23	83.4	6.4671	1.2948
2015	7	28	0	26	52	0.3	1	0.16	98.3	6.4671	0.9007
2015	7	28	0	36	52	0.3	1	0.14	94.1	6.4671	0.7882
2015	7	28	0	46	52	0.3	1	0.15	68	6.4671	0.7882
2015	7	28	0	56	52	0.3	1	0.12	82.3	6.4671	0.6943
2015	7	28	1	6	52	0.3	1	0.13	82.9	6.4671	0.7506
2015	7	28	1	16	52	0.3	1	0.21	112.5	6.4477	1.0849
2015	7	28	1	26	52	0.3	1	0.12	120.7	6.4671	0.6005
2015	7	28	1	36	52	0.3	1	0.16	84.1	6.4671	0.9008
2015	7	28	1	46	52	0.3	1	0.19	96	6.4671	1.0697
2015	7	28	1	56	52	0.3	1	0.21	95.4	6.4671	1.1822
2015	7	28	2	6	52	0.3	1	0.19	98.1	6.4671	1.0509
2015	7	28	2	16	52	0.3	1	0.06	99.5	6.4671	0.3378
2015	7	28	2	26	52	0.3	1	0.18	100.5	6.4671	1.0134
2015	7	28	2	36	52	0.3	1	0.14	100.8	6.4671	0.7882
2015	7	28	2	46	52	0.3	1	0.11	91.7	6.4671	0.6193
2015	7	28	2	56	52	0.3	1	0.17	111.6	6.4671	0.9008
2015	7	28	3	6	52	0.3	1	0.18	90	6.4671	1.0509
2015	7	28	3	16	52	0.3	1	0.16	93.4	6.4671	0.9383
2015	7	28	3	26	52	0.3	1	0.14	72.8	6.4671	0.7882
2015	7	28	3	36	52	0.3	1	0.13	85.5	6.4864	0.7154

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	28	3	46	52	0.3	1	0.17	90	6.4671	0.9946
2015	7	28	3	56	52	0.3	1	0.24	77.1	6.4671	1.3136
2015	7	28	4	6	52	0.3	1	0.19	108.4	6.4864	1.0166
2015	7	28	4	16	52	0.3	1	0.17	103.5	6.4671	0.9383
2015	7	28	4	26	52	0.3	1	0.17	108.8	6.4864	0.9413
2015	7	28	4	36	52	0.3	1	0.23	110.3	6.4864	1.2237
2015	7	28	4	46	52	0.3	1	0.23	80.3	6.4864	1.3179
2015	7	28	4	56	52	0.3	1	0.13	73.4	6.5058	0.6988
2015	7	28	5	6	52	0.3	1	0.12	94.6	6.5058	0.6988
2015	7	28	5	16	52	0.3	1	0.14	84.7	6.5058	0.8121
2015	7	28	5	26	52	0.3	1	0.15	97.8	6.5058	0.831
2015	7	28	5	36	52	0.3	1	0.11	88.4	6.5058	0.661
2015	7	28	5	46	52	0.3	1	0.2	111.4	6.5252	1.0611
2015	7	28	5	56	52	0.3	1	0.26	91.4	6.5252	1.5158
2015	7	28	6	6	52	0.3	1	0.25	90	6.5252	1.4589
2015	7	28	6	16	52	0.3	1	0.28	86.6	6.5252	1.6105
2015	7	28	6	26	52	0.3	1	0.14	95.6	6.5445	0.7793
2015	7	28	6	36	52	0.3	1	0.2	85.2	6.5445	1.1405
2015	7	28	6	46	52	0.3	1	0.16	85.2	6.5445	0.9124
2015	7	28	6	56	52	0.3	1	0.21	98.9	6.5445	1.2165
2015	7	28	7	6	52	0.3	1	0.15	67.3	6.5445	0.8173
2015	7	28	7	16	52	0.3	1	0.16	94.7	6.5445	0.9314
2015	7	28	7	26	52	0.3	1	0.17	90	6.5445	1.0074
2015	7	28	7	36	52	0.3	1	0.07	105.3	6.5445	0.4182
2015	7	28	7	46	52	0.3	1	0.16	90	6.5445	0.9124
2015	7	28	7	56	52	0.3	1	0.15	104.9	6.5445	0.8554
2015	7	28	8	6	52	0.3	1	0.18	92.1	6.5445	1.0264
2015	7	28	8	16	52	0.3	1	0.16	86.4	6.5445	0.9124
2015	7	28	8	26	52	0.3	1	0.15	88.8	6.5445	0.8934
2015	7	28	8	36	52	0.3	1	0.16	70.4	6.5445	0.8553
2015	7	28	8	46	52	0.3	1	0.16	81.9	6.5252	0.9284
2015	7	28	8	56	52	0.3	1	0.22	95.1	6.5445	1.2735
2015	7	28	9	6	52	0.3	1	0.15	88.8	6.5445	0.8934
2015	7	28	9	16	52	0.3	1	0.14	90	6.5445	0.8173

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	28	9	26	52	0.3	1	0.19	101.9	6.5445	1.0834
2015	7	28	9	36	52	0.3	1	0.19	69.1	6.5445	1.0454
2015	7	28	9	46	52	0.3	1	0.19	72.8	6.5445	1.0454
2015	7	28	9	56	52	0.3	1	0.14	91.3	6.5445	0.8173
2015	7	28	10	6	52	0.3	1	0.16	78	6.5445	0.8934
2015	7	28	10	16	52	0.3	1	0.13	99	6.5445	0.7223
2015	7	28	10	26	52	0.3	1	0.23	98.2	6.5445	1.3115
2015	7	28	10	36	52	0.3	1	0.2	71.3	6.5445	1.1214
2015	7	28	10	46	52	0.3	1	0.17	78.7	6.5445	0.9504
2015	7	28	10	56	52	0.3	1	0.19	83.1	6.5445	1.1024
2015	7	28	11	6	52	0.3	1	0.14	67.2	6.5445	0.7223
2015	7	28	11	16	52	0.3	1	0.17	100.2	6.5445	0.9504
2015	7	28	11	26	52	0.3	1	0.23	81.8	6.5445	1.3115
2015	7	28	11	36	52	0.3	1	0.15	90	6.5445	0.8743
2015	7	28	11	46	52	0.3	1	0.18	72.2	6.5252	1.0042
2015	7	28	11	56	52	0.3	1	0.1	84.3	6.5252	0.5684
2015	7	28	12	6	52	0.3	1	0.19	76.7	6.5252	1.0421
2015	7	28	12	16	52	0.3	1	0.19	75.7	6.5252	1.0421
2015	7	28	12	26	52	0.3	1	0.17	84.5	6.5058	0.9821
2015	7	28	12	36	52	0.3	1	0.15	98.7	6.5252	0.8716
2015	7	28	12	46	52	0.3	1	0.19	66.9	6.5252	1.0231
2015	7	28	12	56	52	0.3	1	0.19	69.7	6.5058	1.0199
2015	7	28	13	6	52	0.3	1	0.17	57.5	6.5252	0.8336
2015	7	28	13	16	52	0.3	1	0.2	49	6.5252	0.8715
2015	7	28	13	26	52	0.3	1	0.17	87.8	6.5058	1.001
2015	7	28	13	36	52	0.3	1	0.25	79.4	6.5058	1.4164
2015	7	28	13	46	52	0.3	1	0.2	90.9	6.5058	1.1709
2015	7	28	13	56	52	0.3	1	0.2	69.2	6.4864	1.0919
2015	7	28	14	6	52	0.3	1	0.15	77.7	6.4864	0.866
2015	7	28	14	16	52	0.3	1	0.22	57	6.4864	1.073
2015	7	28	14	26	52	0.3	1	0.3	57.9	6.5058	1.4731
2015	7	28	14	36	52	0.3	1	0.26	60.2	6.4864	1.2801
2015	7	28	14	46	52	0.3	1	0.23	75.2	6.4864	1.2801
2015	7	28	14	56	52	0.3	1	0.24	89.2	6.4864	1.3742

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	28	15	6	52	0.3	1	0.16	84.2	6.4864	0.9224
2015	7	28	15	16	52	0.3	1	0.27	66.3	6.4864	1.4119
2015	7	28	15	26	52	0.3	1	0.17	73.6	6.4864	0.9601
2015	7	28	15	36	52	0.3	1	0.22	73.7	6.4864	1.2236
2015	7	28	15	46	52	0.3	1	0.13	52	6.4864	0.6024
2015	7	28	15	56	52	0.3	1	0.17	64.9	6.4864	0.8848
2015	7	28	16	6	52	0.3	1	0.2	63.4	6.4671	1.0133
2015	7	28	16	16	52	0.3	1	0.19	67.1	6.4671	0.9758
2015	7	28	16	26	52	0.3	1	0.17	58.5	6.4864	0.8283
2015	7	28	16	36	52	0.3	1	0.23	82.7	6.4671	1.3135
2015	7	28	16	46	52	0.3	1	0.18	57.2	6.4864	0.8471
2015	7	28	16	56	52	0.3	1	0.26	89.3	6.4864	1.506
2015	7	28	17	6	52	0.3	1	0.21	67.5	6.4864	1.0919
2015	7	28	17	16	52	0.3	1	0.22	72.4	6.4864	1.186
2015	7	28	17	26	52	0.3	1	0.19	85.2	6.4671	1.1071
2015	7	28	17	36	52	0.3	1	0.17	95.6	6.4864	0.9601
2015	7	28	17	46	52	0.3	1	0.19	54.1	6.4864	0.8848
2015	7	28	17	56	52	0.3	1	0.19	99	6.4864	1.073
2015	7	28	18	6	52	0.3	1	0.19	83.1	6.4864	1.0919
2015	7	28	18	16	52	0.3	1	0.13	77.3	6.4864	0.753
2015	7	28	18	26	52	0.3	1	0.18	63.4	6.4864	0.9036
2015	7	28	18	36	52	0.3	1	0.2	78.7	6.4864	1.1295
2015	7	28	18	46	52	0.3	1	0.13	82.7	6.4671	0.7318
2015	7	28	18	56	52	0.3	1	0.14	86.1	6.4671	0.8256
2015	7	28	19	6	52	0.3	1	0.27	90	6.4671	1.5199
2015	7	28	19	16	52	0.3	1	0.17	96.5	6.4671	0.9945
2015	7	28	19	26	52	0.3	1	0.17	103.5	6.4671	0.9382
2015	7	28	19	36	52	0.3	1	0.14	83.2	6.4671	0.7881
2015	7	28	19	46	52	0.3	1	0.14	91.3	6.4671	0.8256
2015	7	28	19	56	52	0.3	1	0.19	93	6.4864	1.073
2015	7	28	20	6	52	0.3	1	0.27	94.2	6.4864	1.5248
2015	7	28	20	16	52	0.3	1	0.24	104.8	6.4864	1.3554
2015	7	28	20	26	52	0.3	1	0.17	102.4	6.4864	0.9413
2015	7	28	20	36	52	0.3	1	0.25	102.9	6.4864	1.3931

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	28	20	46	52	0.3	1	0.29	97.9	6.4864	1.6378
2015	7	28	20	56	52	0.3	1	0.16	117.6	6.4864	0.8283
2015	7	28	21	6	52	0.3	1	0.17	86.7	6.4864	0.9789
2015	7	28	21	16	52	0.3	1	0.15	108	6.4864	0.8095
2015	7	28	21	26	52	0.3	1	0.17	73	6.4864	0.9224
2015	7	28	21	36	52	0.3	1	0.15	83.7	6.5058	0.8498
2015	7	28	21	46	52	0.3	1	0.07	116.6	6.5058	0.3777
2015	7	28	21	56	52	0.3	1	0.2	106.1	6.4864	1.1107
2015	7	28	22	6	52	0.3	1	0.21	107	6.5058	1.1709
2015	7	28	22	16	52	0.3	1	0.17	87.8	6.5058	1.0009
2015	7	28	22	26	52	0.3	1	0.2	121.6	6.5058	0.9821
2015	7	28	22	36	52	0.3	1	0.2	88.1	6.4864	1.1295
2015	7	28	22	46	52	0.3	1	0.17	93.4	6.5058	0.9632
2015	7	28	22	56	52	0.3	1	0.16	53.4	6.5058	0.7365
2015	7	28	23	6	52	0.3	1	0.1	77.3	6.5058	0.5855
2015	7	28	23	16	52	0.3	1	0.13	74.2	6.5252	0.7389
2015	7	28	23	26	52	0.3	1	0.17	56.9	6.5252	0.8147
2015	7	28	23	36	52	0.3	1	0.15	90	6.5252	0.8526
2015	7	28	23	46	52	0.3	1	0.11	71.6	6.5445	0.6272
2015	7	28	23	56	52	0.3	1	0.14	95.3	6.5252	0.8147
2015	7	29	0	6	52	0.3	1	0.21	30.7	6.5252	0.6063
2015	7	29	0	16	52	0.3	1	0.13	95.9	6.5252	0.7389
2015	7	29	0	26	52	0.3	1	0.12	104	6.5252	0.6821
2015	7	29	0	36	52	0.3	1	0.17	105.6	6.5252	0.9473
2015	7	29	0	46	52	0.3	1	0.09	88	6.5445	0.5322
2015	7	29	0	56	52	0.3	1	0.19	90	6.5445	1.1024
2015	7	29	1	6	52	0.3	1	0.29	91.3	6.5445	1.6536
2015	7	29	1	16	52	0.3	1	0.19	87.1	6.5252	1.1178
2015	7	29	1	26	52	0.3	1	0.23	87.5	6.5445	1.3115
2015	7	29	1	36	52	0.3	1	0.15	68.9	6.5445	0.8363
2015	7	29	1	46	52	0.3	1	0.18	82.5	6.5445	1.0074
2015	7	29	1	56	52	0.3	1	0.16	70.4	6.5252	0.8526
2015	7	29	2	6	52	0.3	1	0.24	72.1	6.5252	1.3452
2015	7	29	2	16	52	0.3	1	0.16	94.7	6.5252	0.9284

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	29	2	26	52	0.3	1	0.17	82	6.5445	0.9504
2015	7	29	2	36	52	0.3	1	0.06	67.6	6.5445	0.3231
2015	7	29	2	46	52	0.3	1	0.16	103.4	6.5445	0.8743
2015	7	29	2	56	52	0.3	1	0.17	140.3	6.5252	0.6442
2015	7	29	3	6	52	0.3	1	0.19	89	6.5252	1.08
2015	7	29	3	16	52	0.3	1	0.16	100.6	6.5252	0.9094
2015	7	29	3	26	52	0.3	1	0.15	88.8	6.5252	0.8905
2015	7	29	3	36	52	0.3	1	0.17	82.2	6.5445	0.9694
2015	7	29	3	46	52	0.3	1	0.1	72.8	6.5445	0.5512
2015	7	29	3	56	52	0.3	1	0.17	115.6	6.5252	0.9095
2015	7	29	4	6	52	0.3	1	0.12	83.7	6.5445	0.6843
2015	7	29	4	16	52	0.3	1	0.16	104	6.5252	0.9095
2015	7	29	4	26	52	0.3	1	0.18	99.6	6.5252	1.0042
2015	7	29	4	36	52	0.3	1	0.12	128.4	6.5252	0.5495
2015	7	29	4	46	52	0.3	1	0.14	90	6.5252	0.8147
2015	7	29	4	56	52	0.3	1	0.14	91.3	6.5252	0.8147
2015	7	29	5	6	52	0.3	1	0.16	105.5	6.5252	0.8905
2015	7	29	5	16	52	0.3	1	0.18	90	6.5252	1.061
2015	7	29	5	26	52	0.3	1	0.22	87.4	6.5252	1.2695
2015	7	29	5	36	52	0.3	1	0.18	103.5	6.5252	1.0231
2015	7	29	5	46	52	0.3	1	0.26	107.3	6.5252	1.4589
2015	7	29	5	56	52	0.3	1	0.2	99.6	6.5252	1.1179
2015	7	29	6	6	52	0.3	1	0.11	106.2	6.5252	0.5874
2015	7	29	6	16	52	0.3	1	0.16	87.7	6.5252	0.9284
2015	7	29	6	26	52	0.3	1	0.14	86.1	6.5252	0.8337
2015	7	29	6	36	52	0.3	1	0.09	33.1	6.5252	0.2842
2015	7	29	6	46	52	0.3	1	0.16	109.2	6.5252	0.8716
2015	7	29	6	56	52	0.3	1	0.2	100.2	6.5252	1.1558
2015	7	29	7	6	52	0.3	1	0.15	116.6	6.5252	0.7579
2015	7	29	7	16	52	0.3	1	0.17	96.5	6.5252	1.0042
2015	7	29	7	26	52	0.3	1	0.17	90	6.5252	0.9663
2015	7	29	7	36	52	0.3	1	0.13	73.4	6.5252	0.701
2015	7	29	7	46	52	0.3	1	0.22	97.9	6.5252	1.2316
2015	7	29	7	56	52	0.3	1	0.18	91.1	6.5445	1.0264

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	29	8	6	52	0.3	1	0.24	81.2	6.5252	1.3453
2015	7	29	8	16	52	0.3	1	0.14	84.4	6.5445	0.7793
2015	7	29	8	26	52	0.3	1	0.18	84.7	6.5445	1.0264
2015	7	29	8	36	52	0.3	1	0.15	104.3	6.5252	0.8147
2015	7	29	8	46	52	0.3	1	0.18	77.7	6.5252	1.0421
2015	7	29	8	56	52	0.3	1	0.18	77.2	6.5252	1.0042
2015	7	29	9	6	52	0.3	1	0.14	76	6.5252	0.7579
2015	7	29	9	16	52	0.3	1	0.07	76	6.5252	0.3789
2015	7	29	9	26	52	0.3	1	0.07	76	6.5252	0.3789
2015	7	29	9	36	52	0.3	1	0.16	106.3	6.5252	0.9095
2015	7	29	9	46	52	0.3	1	0.15	91.2	6.5252	0.8905
2015	7	29	9	56	52	0.3	1	0.16	87.6	6.5252	0.9095
2015	7	29	10	6	52	0.3	1	0.15	116.6	6.5252	0.7579
2015	7	29	10	16	52	0.3	1	0.18	63.4	6.5252	0.9473
2015	7	29	10	26	52	0.3	1	0.21	93.5	6.5252	1.2316
2015	7	29	10	36	52	0.3	1	0.18	107.4	6.5832	0.9755
2015	7	29	10	46	52	0.3	1	0.19	110.3	6.5639	1.0296
2015	7	29	10	56	52	0.3	1	0.13	94.5	6.5639	0.7246
2015	7	29	11	6	52	0.3	1	0.15	83.7	6.5639	0.858
2015	7	29	11	16	52	0.3	1	0.19	82.9	6.5639	1.0678
2015	7	29	11	26	52	0.3	1	0.2	80.4	6.5639	1.125
2015	7	29	11	36	52	0.3	1	0.2	95.5	6.5445	1.1784
2015	7	29	11	46	52	0.3	1	0.22	102.8	6.5252	1.2505
2015	7	29	11	56	52	0.3	1	0.16	93.5	6.5252	0.9284
2015	7	29	12	6	52	0.3	1	0.16	94.7	6.5058	0.9254
2015	7	29	12	16	52	0.3	1	0.12	81.9	6.5058	0.661
2015	7	29	12	26	52	0.3	1	0.19	75.3	6.5058	1.0765
2015	7	29	12	36	52	0.3	1	0.21	74.4	6.4864	1.1484
2015	7	29	12	46	52	0.3	1	0.19	92.9	6.4864	1.1107
2015	7	29	12	56	52	0.3	1	0.21	90	6.4671	1.2198
2015	7	29	13	6	52	0.3	1	0.16	60.8	6.4864	0.8095
2015	7	29	13	16	52	0.3	1	0.22	74.3	6.4671	1.201
2015	7	29	13	26	52	0.3	1	0.13	95.9	6.4671	0.7318
2015	7	29	13	36	52	0.3	1	0.2	68.4	6.4671	1.0884

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	29	13	46	52	0.3	1	0.22	78.9	6.4671	1.2385
2015	7	29	13	56	52	0.3	1	0.14	69.4	6.4671	0.7506
2015	7	29	14	6	52	0.3	1	0.18	59.2	6.4671	0.882
2015	7	29	14	16	52	0.3	1	0.19	79.9	6.4671	1.0508
2015	7	29	14	26	52	0.3	1	0.2	90	6.4671	1.1447
2015	7	29	14	36	52	0.3	1	0.19	66.1	6.4671	0.9758
2015	7	29	14	46	52	0.3	1	0.23	56.8	6.4671	1.0884
2015	7	29	14	56	52	0.3	1	0.21	56.1	6.4477	0.9726
2015	7	29	15	6	52	0.3	1	0.15	62.9	6.4671	0.7694
2015	7	29	15	16	52	0.3	1	0.18	78.3	6.4671	0.9945
2015	7	29	15	26	52	0.3	1	0.18	58.7	6.4671	0.8632
2015	7	29	15	36	52	0.3	1	0.23	85.1	6.4477	1.3093
2015	7	29	15	46	52	0.3	1	0.26	85.7	6.4477	1.4963
2015	7	29	15	56	52	0.3	1	0.1	71.6	6.4671	0.5629
2015	7	29	16	6	52	0.3	1	0.18	80.7	6.4477	1.0287
2015	7	29	16	16	52	0.3	1	0.16	90	6.4477	0.9352
2015	7	29	16	26	52	0.3	1	0.16	119.7	6.4477	0.7856
2015	7	29	16	36	52	0.3	1	0.16	77.3	6.4477	0.9165
2015	7	29	16	46	52	0.3	1	0.2	63	6.4477	1.0287
2015	7	29	16	56	52	0.3	1	0.27	54.5	6.4477	1.2345
2015	7	29	17	6	52	0.3	1	0.25	67.2	6.4477	1.2906
2015	7	29	17	16	52	0.3	1	0.21	63.8	6.4477	1.0661
2015	7	29	17	26	52	0.3	1	0.23	51.8	6.4477	1.0474
2015	7	29	17	36	52	0.3	1	0.2	50.3	6.4477	0.8791
2015	7	29	17	46	52	0.3	1	0.2	68.4	6.4477	1.0848
2015	7	29	17	56	52	0.3	1	0.17	73	6.4477	0.9165
2015	7	29	18	6	52	0.3	1	0.19	83.2	6.4477	1.1035
2015	7	29	18	16	52	0.3	1	0.16	88.8	6.4477	0.9165
2015	7	29	18	26	52	0.3	1	0.15	73.5	6.4477	0.823
2015	7	29	18	36	52	0.3	1	0.12	88.5	6.4477	0.6921
2015	7	29	18	46	52	0.3	1	0.14	76.3	6.4477	0.7669
2015	7	29	18	56	52	0.3	1	0.17	105.6	6.4477	0.9352
2015	7	29	19	6	52	0.3	1	0.17	96.6	6.4477	0.9726
2015	7	29	19	16	52	0.3	1	0.13	92.9	6.4477	0.7482

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	29	19	26	52	0.3	1	0.2	93.8	6.4477	1.1223
2015	7	29	19	36	52	0.3	1	0.11	90	6.4477	0.6546
2015	7	29	19	46	52	0.3	1	0.16	95.8	6.4477	0.9165
2015	7	29	19	56	52	0.3	1	0.13	92.8	6.4477	0.7669
2015	7	29	20	6	52	0.3	1	0.17	91.1	6.4477	0.9726
2015	7	29	20	16	52	0.3	1	0.2	116.6	6.4477	1.01
2015	7	29	20	26	52	0.3	1	0.15	76.3	6.4477	0.8417
2015	7	29	20	36	52	0.3	1	0.17	84.5	6.4477	0.9726
2015	7	29	20	46	52	0.3	1	0.22	94.2	6.4477	1.2719
2015	7	29	20	56	52	0.3	1	0.15	103.7	6.4477	0.8417
2015	7	29	21	6	52	0.3	1	0.17	103.2	6.4477	0.9539
2015	7	29	21	16	52	0.3	1	0.14	90	6.4284	0.8017
2015	7	29	21	26	52	0.3	1	0.12	60.1	6.4477	0.6172
2015	7	29	21	36	52	0.3	1	0.2	68.4	6.4477	1.0849
2015	7	29	21	46	52	0.3	1	0.11	72.6	6.4284	0.5966
2015	7	29	21	56	52	0.3	1	0.18	90	6.4284	1.0254
2015	7	29	22	6	52	0.3	1	0.21	98.3	6.4284	1.1559
2015	7	29	22	16	52	0.3	1	0.15	91.2	6.4284	0.8763
2015	7	29	22	26	52	0.3	1	0.18	89	6.4284	1.0441
2015	7	29	22	36	52	0.3	1	0.13	106.1	6.4284	0.7085
2015	7	29	22	46	52	0.3	1	0.17	101.9	6.4284	0.9695
2015	7	29	22	56	52	0.3	1	0.1	102.7	6.4284	0.578
2015	7	29	23	6	52	0.3	1	0.19	81.2	6.4284	1.0814
2015	7	29	23	16	52	0.3	1	0.19	90	6.4284	1.0814
2015	7	29	23	26	52	0.3	1	0.18	110.8	6.4284	0.9322
2015	7	29	23	36	52	0.3	1	0.19	99	6.4284	1.0627
2015	7	29	23	46	52	0.3	1	0.19	104.3	6.4284	1.0254
2015	7	29	23	56	52	0.3	1	0.14	99.7	6.4284	0.7644
2015	7	30	0	6	52	0.3	1	0.2	90	6.4284	1.1373
2015	7	30	0	16	52	0.3	1	0.11	98.4	6.409	0.6319
2015	7	30	0	26	52	0.3	1	0.16	116	6.4284	0.8017
2015	7	30	0	36	52	0.3	1	0.09	85.6	6.4284	0.4848
2015	7	30	0	46	52	0.3	1	0.11	76.8	6.4284	0.6339
2015	7	30	0	56	52	0.3	1	0.16	98.3	6.4284	0.8949

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	30	1	6	52	0.3	1	0.14	104	6.4284	0.7458
2015	7	30	1	16	52	0.3	1	0.13	97.1	6.4284	0.7458
2015	7	30	1	26	52	0.3	1	0.15	103.7	6.4284	0.839
2015	7	30	1	36	52	0.3	1	0.14	106.3	6.4284	0.7644
2015	7	30	1	46	52	0.3	1	0.23	96.6	6.4284	1.2865
2015	7	30	1	56	52	0.3	1	0.15	105.3	6.409	0.8177
2015	7	30	2	6	52	0.3	1	0.14	103.4	6.4284	0.7831
2015	7	30	2	16	52	0.3	1	0.14	84.4	6.4284	0.7644
2015	7	30	2	26	52	0.3	1	0.23	114	6.4284	1.1746
2015	7	30	2	36	52	0.3	1	0.16	91.2	6.4284	0.9136
2015	7	30	2	46	52	0.3	1	0.03	53.1	6.4284	0.1492
2015	7	30	2	56	52	0.3	1	0.15	97.6	6.4284	0.839
2015	7	30	3	6	52	0.3	1	0.21	81.9	6.4284	1.1746
2015	7	30	3	16	52	0.3	1	0.15	78.9	6.4284	0.8577
2015	7	30	3	26	52	0.3	1	0.19	93	6.4284	1.0628
2015	7	30	3	36	52	0.3	1	0.19	105.9	6.4284	1.0441
2015	7	30	3	46	52	0.3	1	0.19	114.4	6.4284	0.9882
2015	7	30	3	56	52	0.3	1	0.14	111	6.4284	0.7272
2015	7	30	4	6	52	0.3	1	0.21	111.3	6.4284	1.1001
2015	7	30	4	16	52	0.3	1	0.13	111.3	6.4284	0.6712
2015	7	30	4	26	52	0.3	1	0.1	91.9	6.4284	0.5593
2015	7	30	4	36	52	0.3	1	0.19	116.1	6.4284	0.9882
2015	7	30	4	46	52	0.3	1	0.22	92.6	6.4284	1.2306
2015	7	30	4	56	52	0.3	1	0.09	94.2	6.4477	0.505
2015	7	30	5	6	52	0.3	1	0.24	97.9	6.4477	1.3468
2015	7	30	5	16	52	0.3	1	0.19	91	6.4284	1.0628
2015	7	30	5	26	52	0.3	1	0.13	101.3	6.4284	0.7458
2015	7	30	5	36	52	0.3	1	0.12	104	6.4284	0.6712
2015	7	30	5	46	52	0.3	1	0.21	92.7	6.4284	1.1933
2015	7	30	5	56	52	0.3	1	0.16	95.7	6.4284	0.9323
2015	7	30	6	6	52	0.3	1	0.15	95.1	6.4284	0.839
2015	7	30	6	16	52	0.3	1	0.18	69	6.4284	0.9696
2015	7	30	6	26	52	0.3	1	0.15	70.3	6.4477	0.7856
2015	7	30	6	36	52	0.3	1	0.24	58.1	6.4284	1.1374

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	30	6	46	52	0.3	1	0.26	61.8	6.4284	1.2865
2015	7	30	6	56	52	0.3	1	0.14	59.9	6.4284	0.7085
2015	7	30	7	6	52	0.3	1	0.12	123.7	6.4477	0.5612
2015	7	30	7	16	52	0.3	1	0.11	90	6.4477	0.6547
2015	7	30	7	26	52	0.3	1	0.14	101.8	6.4477	0.8043
2015	7	30	7	36	52	0.3	1	0.12	113	6.4477	0.6173
2015	7	30	7	46	52	0.3	1	0.2	99.3	6.4477	1.141
2015	7	30	7	56	52	0.3	1	0.1	97.4	6.4477	0.5799
2015	7	30	8	6	52	0.3	1	0.15	107.3	6.4477	0.8417
2015	7	30	8	16	52	0.3	1	0.18	99.6	6.4477	0.9914
2015	7	30	8	26	52	0.3	1	0.19	108.7	6.4477	1.0475
2015	7	30	8	36	52	0.3	1	0.27	82.3	6.4477	1.5151
2015	7	30	8	46	52	0.3	1	0.15	113.2	6.4477	0.7856
2015	7	30	8	56	52	0.3	1	0.18	75.2	6.4477	0.9914
2015	7	30	9	6	52	0.3	1	0.17	105.6	6.4477	0.9353
2015	7	30	9	16	52	0.3	1	0.15	97.6	6.4477	0.8417
2015	7	30	9	26	52	0.3	1	0.22	100.5	6.4477	1.2159
2015	7	30	9	36	52	0.3	1	0.21	75.7	6.4477	1.1784
2015	7	30	9	46	52	0.3	1	0.21	81.1	6.4477	1.1971
2015	7	30	9	56	52	0.3	1	0.22	97.9	6.4477	1.2158
2015	7	30	10	14	31	0.3	1	0.17	94.5	6.4671	0.957
2015	7	30	10	24	31	0.3	1	0.16	119.2	6.4477	0.8043
2015	7	30	10	34	31	0.3	1	0.14	90	6.4477	0.823
2015	7	30	10	44	31	0.3	1	0.14	104.7	6.4477	0.7856
2015	7	30	10	54	31	0.3	1	0.19	105.9	6.4671	1.0509
2015	7	30	11	4	31	0.3	1	0.18	104.8	6.4477	0.9914
2015	7	30	11	14	31	0.3	1	0.15	91.3	6.4477	0.8417
2015	7	30	11	24	31	0.3	1	0.12	81.9	6.4477	0.6547
2015	7	30	11	34	31	0.3	1	0.14	90	6.4477	0.8043
2015	7	30	11	44	31	0.3	1	0.11	90	6.4477	0.636
2015	7	30	11	54	31	0.3	1	0.19	106.2	6.4477	1.0288
2015	7	30	12	4	31	0.3	1	0.19	90	6.4477	1.0849
2015	7	30	12	14	31	0.3	1	0.21	93.6	6.4477	1.1784
2015	7	30	12	24	31	0.3	1	0.2	106.6	6.4477	1.0662

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	30	12	34	31	0.3	1	0.08	109.2	6.4477	0.4302
2015	7	30	12	44	31	0.3	1	0.09	90	6.4477	0.4863
2015	7	30	12	54	31	0.3	1	0.14	111.3	6.4477	0.7669
2015	7	30	13	4	31	0.3	1	0.22	97.9	6.4477	1.2158
2015	7	30	13	14	31	0.3	1	0.11	98.4	6.4477	0.636
2015	7	30	13	24	31	0.3	1	0.21	85.5	6.4477	1.1784
2015	7	30	13	34	31	0.3	1	0.15	83.5	6.4477	0.823
2015	7	30	13	44	31	0.3	1	0.2	84.4	6.4477	1.141
2015	7	30	13	54	31	0.3	1	0.19	88	6.4477	1.0662
2015	7	30	14	4	31	0.3	1	0.13	90	6.4477	0.7482
2015	7	30	14	14	31	0.3	1	0.16	59.2	6.4477	0.7856
2015	7	30	14	24	31	0.3	1	0.19	88	6.4477	1.0662
2015	7	30	14	34	31	0.3	1	0.2	79.8	6.4477	1.141
2015	7	30	14	44	31	0.3	1	0.16	103.4	6.4477	0.8604
2015	7	30	14	54	31	0.3	1	0.16	92.3	6.4477	0.9352
2015	7	30	15	4	31	0.3	1	0.2	111.1	6.4477	1.0662
2015	7	30	15	14	31	0.3	1	0.12	75.2	6.4477	0.636
2015	7	30	15	24	31	0.3	1	0.18	86.9	6.4477	1.0475
2015	7	30	15	34	31	0.3	1	0.18	78.5	6.4477	1.01
2015	7	30	15	44	31	0.3	1	0.21	86.4	6.4477	1.1971
2015	7	30	15	54	31	0.3	1	0.15	98.8	6.4477	0.8417
2015	7	30	16	4	31	0.3	1	0.22	110.4	6.4477	1.1597
2015	7	30	16	14	31	0.3	1	0.19	90	6.4477	1.0662
2015	7	30	16	24	31	0.3	1	0.19	55.5	6.4284	0.8949
2015	7	30	16	34	31	0.3	1	0.19	60.3	6.4477	0.9165
2015	7	30	16	44	31	0.3	1	0.14	85.9	6.4477	0.7856
2015	7	30	16	54	31	0.3	1	0.19	75.3	6.4477	1.0662
2015	7	30	17	4	31	0.3	1	0.17	78.1	6.4477	0.9726
2015	7	30	17	14	31	0.3	1	0.13	71.6	6.4477	0.7295
2015	7	30	17	24	31	0.3	1	0.17	73	6.4477	0.9165
2015	7	30	17	34	31	0.3	1	0.15	76.3	6.4477	0.8417
2015	7	30	17	44	31	0.3	1	0.21	81	6.4477	1.1784
2015	7	30	17	54	31	0.3	1	0.07	87.4	6.4477	0.4115
2015	7	30	18	4	31	0.3	1	0.17	86.7	6.4477	0.9726

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	30	18	14	31	0.3	1	0.13	94.3	6.4477	0.7482
2015	7	30	18	24	31	0.3	1	0.22	90	6.4477	1.2532
2015	7	30	18	34	31	0.3	1	0.14	92.7	6.4477	0.8043
2015	7	30	18	44	31	0.3	1	0.25	86.2	6.4477	1.4216
2015	7	30	18	54	31	0.3	1	0.19	52.9	6.4477	0.8417
2015	7	30	19	4	31	0.3	1	0.19	75	6.4477	1.0475
2015	7	30	19	14	31	0.3	1	0.17	54.5	6.4477	0.7856
2015	7	30	19	24	31	0.3	1	0.21	89.1	6.4477	1.1971
2015	7	30	19	34	31	0.3	1	0.14	69.4	6.4477	0.7482
2015	7	30	19	44	31	0.3	1	0.2	73.9	6.4477	1.1036
2015	7	30	19	54	31	0.3	1	0.18	62.5	6.4477	0.9352
2015	7	30	20	4	31	0.3	1	0.21	76.6	6.4477	1.1784
2015	7	30	20	14	31	0.3	1	0.21	83.7	6.4477	1.1784
2015	7	30	20	24	31	0.3	1	0.21	80.2	6.4477	1.1971
2015	7	30	20	34	31	0.3	1	0.18	72.6	6.4477	0.9539
2015	7	30	20	44	31	0.3	1	0.26	64.7	6.4477	1.3467
2015	7	30	20	54	31	0.3	1	0.22	63.8	6.4477	1.141
2015	7	30	21	4	31	0.3	1	0.22	85.8	6.4477	1.2719
2015	7	30	21	14	31	0.3	1	0.21	52.6	6.4671	0.957
2015	7	30	21	24	31	0.3	1	0.17	72.3	6.4671	0.9383
2015	7	30	21	34	31	0.3	1	0.18	91.1	6.4671	1.0133
2015	7	30	21	44	31	0.3	1	0.17	66.9	6.4671	0.882
2015	7	30	21	54	31	0.3	1	0.23	56.8	6.4671	1.0884
2015	7	30	22	4	31	0.3	1	0.19	68.2	6.4671	1.0321
2015	7	30	22	14	31	0.3	1	0.22	69.9	6.4671	1.1822
2015	7	30	22	24	31	0.3	1	0.21	44.4	6.4671	0.8444
2015	7	30	22	34	31	0.3	1	0.2	90	6.4671	1.1635
2015	7	30	22	44	31	0.3	1	0.24	63.1	6.4671	1.2197
2015	7	30	22	54	31	0.3	1	0.15	65.1	6.4671	0.7694
2015	7	30	23	4	31	0.3	1	0.19	78.9	6.4671	1.0509
2015	7	30	23	14	31	0.3	1	0.22	67.2	6.4671	1.1635
2015	7	30	23	24	31	0.3	1	0.17	58.1	6.4671	0.8444
2015	7	30	23	34	31	0.3	1	0.19	73.1	6.4671	1.0509
2015	7	30	23	44	31	0.3	1	0.35	80.3	6.4671	1.9704

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	30	23	54	31	0.3	1	0.2	83.6	6.4671	1.1635
2015	7	31	0	4	31	0.3	1	0.26	79.1	6.4671	1.4637
2015	7	31	0	14	31	0.3	1	0.13	82.9	6.4671	0.7506
2015	7	31	0	24	31	0.3	1	0.22	87.4	6.4671	1.2385
2015	7	31	0	34	31	0.3	1	0.24	98.7	6.4671	1.3511
2015	7	31	0	44	31	0.3	1	0.12	93.2	6.4671	0.6756
2015	7	31	0	54	31	0.3	1	0.17	90	6.4671	0.957
2015	7	31	1	4	31	0.3	1	0.21	74.7	6.4671	1.1635
2015	7	31	1	14	31	0.3	1	0.16	90	6.4671	0.9383
2015	7	31	1	24	31	0.3	1	0.17	90	6.4671	0.9758
2015	7	31	1	34	31	0.3	1	0.22	106.8	6.4671	1.1822
2015	7	31	1	44	31	0.3	1	0.26	80.5	6.4671	1.4637
2015	7	31	1	54	31	0.3	1	0.2	90	6.4671	1.1635
2015	7	31	2	4	31	0.3	1	0.16	88.8	6.4864	0.9225
2015	7	31	2	14	31	0.3	1	0.23	53.3	6.4671	1.0321
2015	7	31	2	24	31	0.3	1	0.19	90	6.4671	1.0884
2015	7	31	2	34	31	0.3	1	0.17	90	6.4671	0.9571
2015	7	31	2	44	31	0.3	1	0.15	84.9	6.4864	0.8472
2015	7	31	2	54	31	0.3	1	0.17	92.2	6.4864	0.9978
2015	7	31	3	4	31	0.3	1	0.14	98.1	6.4864	0.7907
2015	7	31	3	14	31	0.3	1	0.13	124.9	6.4671	0.6193
2015	7	31	3	24	31	0.3	1	0.19	102.1	6.4864	1.0543
2015	7	31	3	34	31	0.3	1	0.22	89.1	6.4864	1.2614
2015	7	31	3	44	31	0.3	1	0.15	77.5	6.4864	0.8472
2015	7	31	3	54	31	0.3	1	0.21	88.2	6.4864	1.186
2015	7	31	4	4	31	0.3	1	0.22	112.3	6.4864	1.1484
2015	7	31	4	14	31	0.3	1	0.18	92	6.4864	1.0543
2015	7	31	4	24	31	0.3	1	0.21	105.3	6.5252	1.1747
2015	7	31	4	34	31	0.3	1	0.2	96.5	6.5058	1.1521
2015	7	31	4	44	31	0.3	1	0.22	90	6.5252	1.2884
2015	7	31	4	54	31	0.3	1	0.16	103.4	6.5058	0.8688
2015	7	31	5	4	31	0.3	1	0.14	129.3	6.5058	0.6233
2015	7	31	5	14	31	0.3	1	0.23	111.8	6.5252	1.2315
2015	7	31	5	24	31	0.3	1	0.25	88.5	6.5058	1.4165

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	31	5	34	31	0.3	1	0.18	99.6	6.5252	1.0042
2015	7	31	5	44	31	0.3	1	0.2	91.9	6.5252	1.1558
2015	7	31	5	54	31	0.3	1	0.17	107.7	6.5252	0.9473
2015	7	31	6	4	31	0.3	1	0.16	86.5	6.5252	0.9284
2015	7	31	6	14	31	0.3	1	0.18	90	6.5252	1.061
2015	7	31	6	24	31	0.3	1	0.25	97.5	6.5445	1.4445
2015	7	31	6	34	31	0.3	1	0.25	107.7	6.5252	1.3642
2015	7	31	6	44	31	0.3	1	0.16	102	6.5445	0.8933
2015	7	31	6	54	31	0.3	1	0.2	112.3	6.5445	1.0644
2015	7	31	7	4	31	0.3	1	0.12	85.1	6.5252	0.6631
2015	7	31	7	14	31	0.3	1	0.17	95.5	6.5252	0.9852
2015	7	31	7	24	31	0.3	1	0.29	105.3	6.5252	1.5915
2015	7	31	7	34	31	0.3	1	0.18	108.4	6.5445	0.9694
2015	7	31	7	44	31	0.3	1	0.2	90	6.5252	1.1368
2015	7	31	7	54	31	0.3	1	0.21	79.2	6.5445	1.1975
2015	7	31	8	4	31	0.3	1	0.15	104	6.5445	0.8363
2015	7	31	8	14	31	0.3	1	0.13	67.9	6.5252	0.701
2015	7	31	8	24	31	0.3	1	0.2	77.6	6.5252	1.1179
2015	7	31	8	34	31	0.3	1	0.12	86.8	6.5445	0.6843
2015	7	31	8	44	31	0.3	1	0.24	82	6.5445	1.3495
2015	7	31	8	54	31	0.3	1	0.26	98.1	6.5058	1.4543
2015	7	31	9	4	31	0.3	1	0.26	87.8	6.5252	1.4968
2015	7	31	9	14	31	0.3	1	0.21	91.8	6.5252	1.2316
2015	7	31	9	24	31	0.3	1	0.19	102.8	6.5252	1.08
2015	7	31	9	34	31	0.3	1	0.18	76	6.5252	0.9852
2015	7	31	9	44	31	0.3	1	0.23	99.7	6.5252	1.3263
2015	7	31	9	54	31	0.3	1	0.15	87.5	6.5445	0.8743
2015	7	31	10	4	31	0.3	1	0.14	84.7	6.5252	0.8147
2015	7	31	10	14	31	0.3	1	0.15	88.7	6.5445	0.8553
2015	7	31	10	24	31	0.3	1	0.2	92.8	6.5252	1.1558
2015	7	31	10	34	31	0.3	1	0.13	90	6.5252	0.7768
2015	7	31	10	44	31	0.3	1	0.2	91.9	6.5252	1.1558
2015	7	31	10	54	31	0.3	1	0.15	88.7	6.5252	0.8526
2015	7	31	11	4	31	0.3	1	0.16	87.7	6.5252	0.9473

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	31	11	14	31	0.3	1	0.21	102.5	6.5058	1.1899
2015	7	31	11	24	31	0.3	1	0.16	87.6	6.5252	0.9095
2015	7	31	11	34	31	0.3	1	0.22	74.7	6.5252	1.2505
2015	7	31	11	44	31	0.3	1	0.15	83.5	6.5252	0.8337
2015	7	31	11	54	31	0.3	1	0.2	88.1	6.5252	1.1558
2015	7	31	12	4	31	0.3	1	0.19	90	6.5058	1.1143
2015	7	31	12	14	31	0.3	1	0.2	82.5	6.5058	1.1521
2015	7	31	12	24	31	0.3	1	0.2	80.4	6.5058	1.1143
2015	7	31	12	34	31	0.3	1	0.12	73.6	6.5058	0.6421
2015	7	31	12	44	31	0.3	1	0.16	87.7	6.5058	0.9443
2015	7	31	12	54	31	0.3	1	0.13	75.6	6.5058	0.7366
2015	7	31	13	4	31	0.3	1	0.22	63.1	6.4864	1.1484
2015	7	31	13	14	31	0.3	1	0.13	90	6.4864	0.7719
2015	7	31	13	24	31	0.3	1	0.16	78.5	6.4864	0.9225
2015	7	31	13	34	31	0.3	1	0.21	83.7	6.4864	1.1861
2015	7	31	13	44	31	0.3	1	0.24	86.1	6.4864	1.3743
2015	7	31	13	54	31	0.3	1	0.23	81.6	6.4864	1.2802
2015	7	31	14	4	31	0.3	1	0.21	52	6.4864	0.9413
2015	7	31	14	14	31	0.3	1	0.17	83.4	6.4671	0.9758
2015	7	31	14	24	31	0.3	1	0.18	53.7	6.4671	0.8445
2015	7	31	14	34	31	0.3	1	0.16	71.6	6.4671	0.8445
2015	7	31	14	44	31	0.3	1	0.21	67	6.4671	1.1072
2015	7	31	14	54	31	0.3	1	0.14	79.2	6.4671	0.7882
2015	7	31	15	4	31	0.3	1	0.18	77.2	6.4671	0.9946
2015	7	31	15	14	31	0.3	1	0.21	70.2	6.4671	1.1447
2015	7	31	15	24	31	0.3	1	0.16	94.8	6.4671	0.9007
2015	7	31	15	34	31	0.3	1	0.15	60.1	6.4671	0.7506
2015	7	31	15	44	31	0.3	1	0.15	79.9	6.4671	0.8444
2015	7	31	15	54	31	0.3	1	0.22	85.7	6.4477	1.2345
2015	7	31	16	4	31	0.3	1	0.17	98	6.4477	0.9353
2015	7	31	16	14	31	0.3	1	0.13	72.9	6.4671	0.7319
2015	7	31	16	24	31	0.3	1	0.21	77.5	6.4671	1.1822
2015	7	31	16	34	31	0.3	1	0.22	80.4	6.4477	1.2158
2015	7	31	16	44	31	0.3	1	0.15	54.2	6.4477	0.6734

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	31	16	54	31	0.3	1	0.15	81.3	6.4477	0.8604
2015	7	31	17	4	31	0.3	1	0.12	91.5	6.4477	0.6921
2015	7	31	17	14	31	0.3	1	0.23	94	6.4477	1.3281
2015	7	31	17	24	31	0.3	1	0.14	66.4	6.4477	0.7295
2015	7	31	17	34	31	0.3	1	0.18	65.8	6.4477	0.9166
2015	7	31	17	44	31	0.3	1	0.22	95.2	6.4477	1.2345
2015	7	31	17	54	31	0.3	1	0.27	89.3	6.4477	1.5151
2015	7	31	18	4	31	0.3	1	0.16	111.8	6.4477	0.8417
2015	7	31	18	14	31	0.3	1	0.16	90	6.4284	0.9322
2015	7	31	18	24	31	0.3	1	0.15	93.8	6.4477	0.8417
2015	7	31	18	34	31	0.3	1	0.12	83.7	6.4477	0.6734
2015	7	31	18	44	31	0.3	1	0.19	81.2	6.4477	1.0849
2015	7	31	18	54	31	0.3	1	0.17	91.1	6.4284	0.9509
2015	7	31	19	4	31	0.3	1	0.17	97.8	6.4477	0.954
2015	7	31	19	14	31	0.3	1	0.18	104	6.4477	0.9727
2015	7	31	19	24	31	0.3	1	0.22	96	6.4477	1.2532
2015	7	31	19	34	31	0.3	1	0.22	112.3	6.4284	1.1373
2015	7	31	19	44	31	0.3	1	0.21	90	6.4477	1.1784
2015	7	31	19	54	31	0.3	1	0.17	113.6	6.4477	0.8978
2015	7	31	20	4	31	0.3	1	0.17	121	6.4477	0.8417
2015	7	31	20	14	31	0.3	1	0.14	83.2	6.4477	0.7856
2015	7	31	20	24	31	0.3	1	0.22	89.1	6.4477	1.2345
2015	7	31	20	34	31	0.3	1	0.14	112.3	6.4477	0.7295
2015	7	31	20	44	31	0.3	1	0.18	98.4	6.4477	1.0101
2015	7	31	20	54	31	0.3	1	0.12	104	6.4477	0.6734
2015	7	31	21	4	31	0.3	1	0.26	85.6	6.4477	1.459
2015	7	31	21	14	31	0.3	1	0.17	73	6.4477	0.9166
2015	7	31	21	24	31	0.3	1	0.21	90	6.4477	1.1971
2015	7	31	21	34	31	0.3	1	0.23	85.9	6.4477	1.3094
2015	7	31	21	44	31	0.3	1	0.17	88.9	6.4477	0.954
2015	7	31	21	54	31	0.3	1	0.2	68.6	6.4477	1.0475
2015	7	31	22	4	31	0.3	1	0.15	82.4	6.4477	0.8417
2015	7	31	22	14	31	0.3	1	0.18	101.7	6.4477	0.9914
2015	7	31	22	24	31	0.3	1	0.19	96	6.4477	1.0662

Blackrock Return (0208)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	31	22	34	31	0.3	1	0.23	85	6.4477	1.2907
2015	7	31	22	44	31	0.3	1	0.15	96.3	6.4477	0.8417
2015	7	31	22	54	31	0.3	1	0.15	73.5	6.4477	0.823
2015	7	31	23	4	31	0.3	1	0.16	90	6.4477	0.8979
2015	7	31	23	14	31	0.3	1	0.16	129.2	6.4864	0.7154
2015	7	31	23	24	31	0.3	1	0.16	83	6.4477	0.9166
2015	7	31	23	34	31	0.3	1	0.14	112.8	6.4477	0.7108
2015	7	31	23	44	31	0.3	1	0.2	108.7	6.4477	1.1036
2015	7	31	23	54	31	0.3	1	0.25	80.9	6.4477	1.4029

Goose Lake Return

Station 0367

Date	Flow (cfs)
7/1/2015	1.066
7/2/2015	1.131
7/3/2015	1.209
7/4/2015	1.242
7/5/2015	1.246
7/6/2015	1.194
7/7/2015	1.154
7/8/2015	1.081
7/9/2015	1.006
7/10/2015	1.046
7/11/2015	1.179
7/12/2015	1.203
7/13/2015	1.155
7/14/2015	1.08
7/15/2015	1.021
7/16/2015	0.955
7/17/2015	0.958
7/18/2015	0.936
7/19/2015	0.946
7/20/2015	1.009
7/21/2015	1.106
7/22/2015	1.18
7/23/2015	1.185
7/24/2015	1.177
7/25/2015	1.156
7/26/2015	1.098
7/27/2015	1.06
7/28/2015	0.99
7/29/2015	0.955
7/30/2015	0.958
7/31/2015	1.047

Goose Lake Return Gage

DATE	TIME	GAGE
7/1/2015	12:00:00 AM	0.42
7/1/2015	12:15:00 AM	0.43
7/1/2015	12:30:00 AM	0.43
7/1/2015	12:45:00 AM	0.43
7/1/2015	1:00:00 AM	0.43
7/1/2015	1:15:00 AM	0.43
7/1/2015	1:30:00 AM	0.43
7/1/2015	1:45:00 AM	0.43
7/1/2015	2:00:00 AM	0.43
7/1/2015	2:15:00 AM	0.43
7/1/2015	2:30:00 AM	0.43
7/1/2015	2:45:00 AM	0.43
7/1/2015	3:00:00 AM	0.43
7/1/2015	3:15:00 AM	0.43
7/1/2015	3:30:00 AM	0.43
7/1/2015	3:45:00 AM	0.43
7/1/2015	4:00:00 AM	0.43
7/1/2015	4:15:00 AM	0.43
7/1/2015	4:30:00 AM	0.43
7/1/2015	4:45:00 AM	0.43
7/1/2015	5:00:00 AM	0.43
7/1/2015	5:15:00 AM	0.43
7/1/2015	5:30:00 AM	0.43
7/1/2015	5:45:00 AM	0.43
7/1/2015	6:00:00 AM	0.43
7/1/2015	6:15:00 AM	0.43
7/1/2015	6:30:00 AM	0.43
7/1/2015	6:45:00 AM	0.43
7/1/2015	7:00:00 AM	0.43
7/1/2015	7:15:00 AM	0.43
7/1/2015	7:30:00 AM	0.43
7/1/2015	7:45:00 AM	0.43
7/1/2015	8:00:00 AM	0.43
7/1/2015	8:15:00 AM	0.43
7/1/2015	8:30:00 AM	0.43
7/1/2015	8:45:00 AM	0.43
7/1/2015	9:00:00 AM	0.43
7/1/2015	9:15:00 AM	0.43
7/1/2015	9:30:00 AM	0.43
7/1/2015	9:45:00 AM	0.43
7/1/2015	10:00:00 AM	0.43
7/1/2015	10:15:00 AM	0.43
7/1/2015	10:30:00 AM	0.43
7/1/2015	10:45:00 AM	0.43
7/1/2015	11:00:00 AM	0.44
7/1/2015	11:15:00 AM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
7/1/2015	11:30:00 AM	0.43
7/1/2015	11:45:00 AM	0.44
7/1/2015	12:00:00 PM	0.43
7/1/2015	12:15:00 PM	0.44
7/1/2015	12:30:00 PM	0.44
7/1/2015	12:45:00 PM	0.43
7/1/2015	1:00:00 PM	0.43
7/1/2015	1:15:00 PM	0.43
7/1/2015	1:30:00 PM	0.43
7/1/2015	1:45:00 PM	0.43
7/1/2015	2:00:00 PM	0.43
7/1/2015	2:15:00 PM	0.43
7/1/2015	2:30:00 PM	0.43
7/1/2015	2:45:00 PM	0.43
7/1/2015	3:00:00 PM	0.43
7/1/2015	3:15:00 PM	0.43
7/1/2015	3:30:00 PM	0.43
7/1/2015	3:45:00 PM	0.43
7/1/2015	4:00:00 PM	0.43
7/1/2015	4:15:00 PM	0.43
7/1/2015	4:30:00 PM	0.43
7/1/2015	4:45:00 PM	0.43
7/1/2015	5:00:00 PM	0.43
7/1/2015	5:15:00 PM	0.43
7/1/2015	5:30:00 PM	0.43
7/1/2015	5:45:00 PM	0.42
7/1/2015	6:00:00 PM	0.42
7/1/2015	6:15:00 PM	0.43
7/1/2015	6:30:00 PM	0.43
7/1/2015	6:45:00 PM	0.43
7/1/2015	7:00:00 PM	0.43
7/1/2015	7:15:00 PM	0.43
7/1/2015	7:30:00 PM	0.42
7/1/2015	7:45:00 PM	0.42
7/1/2015	8:00:00 PM	0.42
7/1/2015	8:15:00 PM	0.42
7/1/2015	8:30:00 PM	0.42
7/1/2015	8:45:00 PM	0.42
7/1/2015	9:00:00 PM	0.42
7/1/2015	9:15:00 PM	0.43
7/1/2015	9:30:00 PM	0.43
7/1/2015	9:45:00 PM	0.43
7/1/2015	10:00:00 PM	0.43
7/1/2015	10:15:00 PM	0.43
7/1/2015	10:30:00 PM	0.43
7/1/2015	10:45:00 PM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
7/1/2015	11:00:00 PM	0.43
7/1/2015	11:15:00 PM	0.43
7/1/2015	11:30:00 PM	0.43
7/1/2015	11:45:00 PM	0.43
7/2/2015	12:00:00 AM	0.43
7/2/2015	12:15:00 AM	0.43
7/2/2015	12:30:00 AM	0.43
7/2/2015	12:45:00 AM	0.43
7/2/2015	1:00:00 AM	0.43
7/2/2015	1:15:00 AM	0.43
7/2/2015	1:30:00 AM	0.43
7/2/2015	1:45:00 AM	0.43
7/2/2015	2:00:00 AM	0.43
7/2/2015	2:15:00 AM	0.43
7/2/2015	2:30:00 AM	0.43
7/2/2015	2:45:00 AM	0.43
7/2/2015	3:00:00 AM	0.43
7/2/2015	3:15:00 AM	0.43
7/2/2015	3:30:00 AM	0.43
7/2/2015	3:45:00 AM	0.43
7/2/2015	4:00:00 AM	0.43
7/2/2015	4:15:00 AM	0.43
7/2/2015	4:30:00 AM	0.44
7/2/2015	4:45:00 AM	0.45
7/2/2015	5:00:00 AM	0.45
7/2/2015	5:15:00 AM	0.45
7/2/2015	5:30:00 AM	0.45
7/2/2015	5:45:00 AM	0.45
7/2/2015	6:00:00 AM	0.45
7/2/2015	6:15:00 AM	0.45
7/2/2015	6:30:00 AM	0.45
7/2/2015	6:45:00 AM	0.45
7/2/2015	7:00:00 AM	0.45
7/2/2015	7:15:00 AM	0.45
7/2/2015	7:30:00 AM	0.45
7/2/2015	7:45:00 AM	0.45
7/2/2015	8:00:00 AM	0.45
7/2/2015	8:15:00 AM	0.45
7/2/2015	8:30:00 AM	0.45
7/2/2015	8:45:00 AM	0.45
7/2/2015	9:00:00 AM	0.45
7/2/2015	9:15:00 AM	0.45
7/2/2015	9:30:00 AM	0.45
7/2/2015	9:45:00 AM	0.45
7/2/2015	10:00:00 AM	0.45
7/2/2015	10:15:00 AM	0.45

Goose Lake Return Gage

DATE	TIME	GAGE
7/2/2015	10:30:00 AM	0.45
7/2/2015	10:45:00 AM	0.45
7/2/2015	11:00:00 AM	0.45
7/2/2015	11:15:00 AM	0.45
7/2/2015	11:30:00 AM	0.45
7/2/2015	11:45:00 AM	0.45
7/2/2015	12:00:00 PM	0.45
7/2/2015	12:15:00 PM	0.45
7/2/2015	12:30:00 PM	0.45
7/2/2015	12:45:00 PM	0.45
7/2/2015	1:00:00 PM	0.45
7/2/2015	1:15:00 PM	0.45
7/2/2015	1:30:00 PM	0.45
7/2/2015	1:45:00 PM	0.45
7/2/2015	2:00:00 PM	0.45
7/2/2015	2:15:00 PM	0.45
7/2/2015	2:30:00 PM	0.45
7/2/2015	2:45:00 PM	0.45
7/2/2015	3:00:00 PM	0.45
7/2/2015	3:15:00 PM	0.45
7/2/2015	3:30:00 PM	0.45
7/2/2015	3:45:00 PM	0.45
7/2/2015	4:00:00 PM	0.45
7/2/2015	4:15:00 PM	0.45
7/2/2015	4:30:00 PM	0.45
7/2/2015	4:45:00 PM	0.45
7/2/2015	5:00:00 PM	0.45
7/2/2015	5:15:00 PM	0.45
7/2/2015	5:30:00 PM	0.45
7/2/2015	5:45:00 PM	0.45
7/2/2015	6:00:00 PM	0.45
7/2/2015	6:15:00 PM	0.45
7/2/2015	6:30:00 PM	0.45
7/2/2015	6:45:00 PM	0.45
7/2/2015	7:00:00 PM	0.45
7/2/2015	7:15:00 PM	0.45
7/2/2015	7:30:00 PM	0.45
7/2/2015	7:45:00 PM	0.45
7/2/2015	8:00:00 PM	0.45
7/2/2015	8:15:00 PM	0.45
7/2/2015	8:30:00 PM	0.45
7/2/2015	8:45:00 PM	0.45
7/2/2015	9:00:00 PM	0.45
7/2/2015	9:15:00 PM	0.45
7/2/2015	9:30:00 PM	0.45
7/2/2015	9:45:00 PM	0.45

Goose Lake Return Gage

DATE	TIME	GAGE
7/2/2015	10:00:00 PM	0.45
7/2/2015	10:15:00 PM	0.45
7/2/2015	10:30:00 PM	0.45
7/2/2015	10:45:00 PM	0.45
7/2/2015	11:00:00 PM	0.45
7/2/2015	11:15:00 PM	0.45
7/2/2015	11:30:00 PM	0.45
7/2/2015	11:45:00 PM	0.45
7/3/2015	12:00:00 AM	0.45
7/3/2015	12:15:00 AM	0.45
7/3/2015	12:30:00 AM	0.45
7/3/2015	12:45:00 AM	0.45
7/3/2015	1:00:00 AM	0.45
7/3/2015	1:15:00 AM	0.45
7/3/2015	1:30:00 AM	0.45
7/3/2015	1:45:00 AM	0.46
7/3/2015	2:00:00 AM	0.46
7/3/2015	2:15:00 AM	0.46
7/3/2015	2:30:00 AM	0.46
7/3/2015	2:45:00 AM	0.46
7/3/2015	3:00:00 AM	0.46
7/3/2015	3:15:00 AM	0.46
7/3/2015	3:30:00 AM	0.46
7/3/2015	3:45:00 AM	0.46
7/3/2015	4:00:00 AM	0.46
7/3/2015	4:15:00 AM	0.46
7/3/2015	4:30:00 AM	0.46
7/3/2015	4:45:00 AM	0.46
7/3/2015	5:00:00 AM	0.46
7/3/2015	5:15:00 AM	0.47
7/3/2015	5:30:00 AM	0.47
7/3/2015	5:45:00 AM	0.47
7/3/2015	6:00:00 AM	0.47
7/3/2015	6:15:00 AM	0.47
7/3/2015	6:30:00 AM	0.47
7/3/2015	6:45:00 AM	0.47
7/3/2015	7:00:00 AM	0.47
7/3/2015	7:15:00 AM	0.47
7/3/2015	7:30:00 AM	0.47
7/3/2015	7:45:00 AM	0.47
7/3/2015	8:00:00 AM	0.47
7/3/2015	8:15:00 AM	0.47
7/3/2015	8:30:00 AM	0.47
7/3/2015	8:45:00 AM	0.47
7/3/2015	9:00:00 AM	0.47
7/3/2015	9:15:00 AM	0.47

Goose Lake Return Gage

DATE	TIME	GAGE
7/3/2015	9:30:00 AM	0.47
7/3/2015	9:45:00 AM	0.47
7/3/2015	10:00:00 AM	0.47
7/3/2015	10:15:00 AM	0.47
7/3/2015	10:30:00 AM	0.47
7/3/2015	10:45:00 AM	0.47
7/3/2015	11:00:00 AM	0.47
7/3/2015	11:15:00 AM	0.47
7/3/2015	11:30:00 AM	0.47
7/3/2015	11:45:00 AM	0.47
7/3/2015	12:00:00 PM	0.47
7/3/2015	12:15:00 PM	0.47
7/3/2015	12:30:00 PM	0.47
7/3/2015	12:45:00 PM	0.47
7/3/2015	1:00:00 PM	0.47
7/3/2015	1:15:00 PM	0.47
7/3/2015	1:30:00 PM	0.47
7/3/2015	1:45:00 PM	0.47
7/3/2015	2:00:00 PM	0.47
7/3/2015	2:15:00 PM	0.47
7/3/2015	2:30:00 PM	0.47
7/3/2015	2:45:00 PM	0.47
7/3/2015	3:00:00 PM	0.47
7/3/2015	3:15:00 PM	0.47
7/3/2015	3:30:00 PM	0.47
7/3/2015	3:45:00 PM	0.46
7/3/2015	4:00:00 PM	0.46
7/3/2015	4:15:00 PM	0.47
7/3/2015	4:30:00 PM	0.47
7/3/2015	4:45:00 PM	0.47
7/3/2015	5:00:00 PM	0.47
7/3/2015	5:15:00 PM	0.47
7/3/2015	5:30:00 PM	0.46
7/3/2015	5:45:00 PM	0.46
7/3/2015	6:00:00 PM	0.46
7/3/2015	6:15:00 PM	0.46
7/3/2015	6:30:00 PM	0.46
7/3/2015	6:45:00 PM	0.46
7/3/2015	7:00:00 PM	0.46
7/3/2015	7:15:00 PM	0.47
7/3/2015	7:30:00 PM	0.46
7/3/2015	7:45:00 PM	0.46
7/3/2015	8:00:00 PM	0.47
7/3/2015	8:15:00 PM	0.47
7/3/2015	8:30:00 PM	0.47
7/3/2015	8:45:00 PM	0.47

Goose Lake Return Gage

DATE	TIME	GAGE
7/3/2015	9:00:00 PM	0.47
7/3/2015	9:15:00 PM	0.47
7/3/2015	9:30:00 PM	0.47
7/3/2015	9:45:00 PM	0.46
7/3/2015	10:00:00 PM	0.47
7/3/2015	10:15:00 PM	0.47
7/3/2015	10:30:00 PM	0.47
7/3/2015	10:45:00 PM	0.47
7/3/2015	11:00:00 PM	0.47
7/3/2015	11:15:00 PM	0.47
7/3/2015	11:30:00 PM	0.47
7/3/2015	11:45:00 PM	0.47
7/4/2015	12:00:00 AM	0.47
7/4/2015	12:15:00 AM	0.47
7/4/2015	12:30:00 AM	0.47
7/4/2015	12:45:00 AM	0.47
7/4/2015	1:00:00 AM	0.47
7/4/2015	1:15:00 AM	0.47
7/4/2015	1:30:00 AM	0.47
7/4/2015	1:45:00 AM	0.47
7/4/2015	2:00:00 AM	0.47
7/4/2015	2:15:00 AM	0.47
7/4/2015	2:30:00 AM	0.47
7/4/2015	2:45:00 AM	0.47
7/4/2015	3:00:00 AM	0.47
7/4/2015	3:15:00 AM	0.47
7/4/2015	3:30:00 AM	0.47
7/4/2015	3:45:00 AM	0.47
7/4/2015	4:00:00 AM	0.47
7/4/2015	4:15:00 AM	0.47
7/4/2015	4:30:00 AM	0.47
7/4/2015	4:45:00 AM	0.48
7/4/2015	5:00:00 AM	0.48
7/4/2015	5:15:00 AM	0.48
7/4/2015	5:30:00 AM	0.48
7/4/2015	5:45:00 AM	0.48
7/4/2015	6:00:00 AM	0.48
7/4/2015	6:15:00 AM	0.48
7/4/2015	6:30:00 AM	0.48
7/4/2015	6:45:00 AM	0.48
7/4/2015	7:00:00 AM	0.48
7/4/2015	7:15:00 AM	0.48
7/4/2015	7:30:00 AM	0.48
7/4/2015	7:45:00 AM	0.48
7/4/2015	8:00:00 AM	0.48
7/4/2015	8:15:00 AM	0.48

Goose Lake Return Gage

DATE	TIME	GAGE
7/4/2015	8:30:00 AM	0.49
7/4/2015	8:45:00 AM	0.48
7/4/2015	9:00:00 AM	0.48
7/4/2015	9:15:00 AM	0.48
7/4/2015	9:30:00 AM	0.48
7/4/2015	9:45:00 AM	0.48
7/4/2015	10:00:00 AM	0.48
7/4/2015	10:15:00 AM	0.48
7/4/2015	10:30:00 AM	0.48
7/4/2015	10:45:00 AM	0.48
7/4/2015	11:00:00 AM	0.48
7/4/2015	11:15:00 AM	0.48
7/4/2015	11:30:00 AM	0.48
7/4/2015	11:45:00 AM	0.48
7/4/2015	12:00:00 PM	0.48
7/4/2015	12:15:00 PM	0.48
7/4/2015	12:30:00 PM	0.48
7/4/2015	12:45:00 PM	0.48
7/4/2015	1:00:00 PM	0.48
7/4/2015	1:15:00 PM	0.48
7/4/2015	1:30:00 PM	0.48
7/4/2015	1:45:00 PM	0.48
7/4/2015	2:00:00 PM	0.47
7/4/2015	2:15:00 PM	0.47
7/4/2015	2:30:00 PM	0.47
7/4/2015	2:45:00 PM	0.47
7/4/2015	3:00:00 PM	0.47
7/4/2015	3:15:00 PM	0.47
7/4/2015	3:30:00 PM	0.48
7/4/2015	3:45:00 PM	0.47
7/4/2015	4:00:00 PM	0.47
7/4/2015	4:15:00 PM	0.47
7/4/2015	4:30:00 PM	0.47
7/4/2015	4:45:00 PM	0.47
7/4/2015	5:00:00 PM	0.47
7/4/2015	5:15:00 PM	0.47
7/4/2015	5:30:00 PM	0.47
7/4/2015	5:45:00 PM	0.47
7/4/2015	6:00:00 PM	0.47
7/4/2015	6:15:00 PM	0.47
7/4/2015	6:30:00 PM	0.47
7/4/2015	6:45:00 PM	0.47
7/4/2015	7:00:00 PM	0.47
7/4/2015	7:15:00 PM	0.47
7/4/2015	7:30:00 PM	0.47
7/4/2015	7:45:00 PM	0.47

Goose Lake Return Gage

DATE	TIME	GAGE
7/4/2015	8:00:00 PM	0.47
7/4/2015	8:15:00 PM	0.47
7/4/2015	8:30:00 PM	0.47
7/4/2015	8:45:00 PM	0.47
7/4/2015	9:00:00 PM	0.47
7/4/2015	9:15:00 PM	0.47
7/4/2015	9:30:00 PM	0.47
7/4/2015	9:45:00 PM	0.47
7/4/2015	10:00:00 PM	0.47
7/4/2015	10:15:00 PM	0.47
7/4/2015	10:30:00 PM	0.47
7/4/2015	10:45:00 PM	0.47
7/4/2015	11:00:00 PM	0.47
7/4/2015	11:15:00 PM	0.47
7/4/2015	11:30:00 PM	0.47
7/4/2015	11:45:00 PM	0.47
7/5/2015	12:00:00 AM	0.47
7/5/2015	12:15:00 AM	0.47
7/5/2015	12:30:00 AM	0.47
7/5/2015	12:45:00 AM	0.47
7/5/2015	1:00:00 AM	0.47
7/5/2015	1:15:00 AM	0.47
7/5/2015	1:30:00 AM	0.47
7/5/2015	1:45:00 AM	0.48
7/5/2015	2:00:00 AM	0.48
7/5/2015	2:15:00 AM	0.48
7/5/2015	2:30:00 AM	0.48
7/5/2015	2:45:00 AM	0.48
7/5/2015	3:00:00 AM	0.48
7/5/2015	3:15:00 AM	0.48
7/5/2015	3:30:00 AM	0.48
7/5/2015	3:45:00 AM	0.48
7/5/2015	4:00:00 AM	0.48
7/5/2015	4:15:00 AM	0.48
7/5/2015	4:30:00 AM	0.48
7/5/2015	4:45:00 AM	0.48
7/5/2015	5:00:00 AM	0.48
7/5/2015	5:15:00 AM	0.48
7/5/2015	5:30:00 AM	0.47
7/5/2015	5:45:00 AM	0.48
7/5/2015	6:00:00 AM	0.48
7/5/2015	6:15:00 AM	0.48
7/5/2015	6:30:00 AM	0.48
7/5/2015	6:45:00 AM	0.48
7/5/2015	7:00:00 AM	0.48
7/5/2015	7:15:00 AM	0.48

Goose Lake Return Gage

DATE	TIME	GAGE
7/5/2015	7:30:00 AM	0.48
7/5/2015	7:45:00 AM	0.48
7/5/2015	8:00:00 AM	0.48
7/5/2015	8:15:00 AM	0.49
7/5/2015	8:30:00 AM	0.49
7/5/2015	8:45:00 AM	0.49
7/5/2015	9:00:00 AM	0.49
7/5/2015	9:15:00 AM	0.49
7/5/2015	9:30:00 AM	0.49
7/5/2015	9:45:00 AM	0.49
7/5/2015	10:00:00 AM	0.49
7/5/2015	10:15:00 AM	0.48
7/5/2015	10:30:00 AM	0.49
7/5/2015	10:45:00 AM	0.49
7/5/2015	11:00:00 AM	0.48
7/5/2015	11:15:00 AM	0.48
7/5/2015	11:30:00 AM	0.48
7/5/2015	11:45:00 AM	0.48
7/5/2015	12:00:00 PM	0.47
7/5/2015	12:15:00 PM	0.47
7/5/2015	12:30:00 PM	0.47
7/5/2015	12:45:00 PM	0.47
7/5/2015	1:00:00 PM	0.47
7/5/2015	1:15:00 PM	0.47
7/5/2015	1:30:00 PM	0.47
7/5/2015	1:45:00 PM	0.47
7/5/2015	2:00:00 PM	0.47
7/5/2015	2:15:00 PM	0.47
7/5/2015	2:30:00 PM	0.47
7/5/2015	2:45:00 PM	0.47
7/5/2015	3:00:00 PM	0.47
7/5/2015	3:15:00 PM	0.47
7/5/2015	3:30:00 PM	0.47
7/5/2015	3:45:00 PM	0.47
7/5/2015	4:00:00 PM	0.47
7/5/2015	4:15:00 PM	0.47
7/5/2015	4:30:00 PM	0.47
7/5/2015	4:45:00 PM	0.47
7/5/2015	5:00:00 PM	0.47
7/5/2015	5:15:00 PM	0.47
7/5/2015	5:30:00 PM	0.47
7/5/2015	5:45:00 PM	0.47
7/5/2015	6:00:00 PM	0.47
7/5/2015	6:15:00 PM	0.47
7/5/2015	6:30:00 PM	0.47
7/5/2015	6:45:00 PM	0.47

Goose Lake Return Gage

DATE	TIME	GAGE
7/5/2015	7:00:00 PM	0.47
7/5/2015	7:15:00 PM	0.47
7/5/2015	7:30:00 PM	0.47
7/5/2015	7:45:00 PM	0.47
7/5/2015	8:00:00 PM	0.46
7/5/2015	8:15:00 PM	0.47
7/5/2015	8:30:00 PM	0.47
7/5/2015	8:45:00 PM	0.46
7/5/2015	9:00:00 PM	0.47
7/5/2015	9:15:00 PM	0.47
7/5/2015	9:30:00 PM	0.47
7/5/2015	9:45:00 PM	0.47
7/5/2015	10:00:00 PM	0.47
7/5/2015	10:15:00 PM	0.47
7/5/2015	10:30:00 PM	0.47
7/5/2015	10:45:00 PM	0.47
7/5/2015	11:00:00 PM	0.47
7/5/2015	11:15:00 PM	0.47
7/5/2015	11:30:00 PM	0.47
7/5/2015	11:45:00 PM	0.47
7/6/2015	12:00:00 AM	0.47
7/6/2015	12:15:00 AM	0.47
7/6/2015	12:30:00 AM	0.47
7/6/2015	12:45:00 AM	0.47
7/6/2015	1:00:00 AM	0.47
7/6/2015	1:15:00 AM	0.47
7/6/2015	1:30:00 AM	0.47
7/6/2015	1:45:00 AM	0.47
7/6/2015	2:00:00 AM	0.47
7/6/2015	2:15:00 AM	0.47
7/6/2015	2:30:00 AM	0.47
7/6/2015	2:45:00 AM	0.47
7/6/2015	3:00:00 AM	0.47
7/6/2015	3:15:00 AM	0.47
7/6/2015	3:30:00 AM	0.47
7/6/2015	3:45:00 AM	0.47
7/6/2015	4:00:00 AM	0.47
7/6/2015	4:15:00 AM	0.47
7/6/2015	4:30:00 AM	0.47
7/6/2015	4:45:00 AM	0.47
7/6/2015	5:00:00 AM	0.47
7/6/2015	5:15:00 AM	0.47
7/6/2015	5:30:00 AM	0.47
7/6/2015	5:45:00 AM	0.47
7/6/2015	6:00:00 AM	0.47
7/6/2015	6:15:00 AM	0.47

Goose Lake Return Gage

DATE	TIME	GAGE
7/6/2015	6:30:00 AM	0.47
7/6/2015	6:45:00 AM	0.47
7/6/2015	7:00:00 AM	0.47
7/6/2015	7:15:00 AM	0.47
7/6/2015	7:30:00 AM	0.47
7/6/2015	7:45:00 AM	0.47
7/6/2015	8:00:00 AM	0.47
7/6/2015	8:15:00 AM	0.47
7/6/2015	8:30:00 AM	0.47
7/6/2015	8:45:00 AM	0.47
7/6/2015	9:00:00 AM	0.47
7/6/2015	9:15:00 AM	0.47
7/6/2015	9:30:00 AM	0.47
7/6/2015	9:45:00 AM	0.47
7/6/2015	10:00:00 AM	0.47
7/6/2015	10:15:00 AM	0.47
7/6/2015	10:30:00 AM	0.47
7/6/2015	10:45:00 AM	0.47
7/6/2015	11:00:00 AM	0.47
7/6/2015	11:15:00 AM	0.47
7/6/2015	11:30:00 AM	0.47
7/6/2015	11:45:00 AM	0.47
7/6/2015	12:00:00 PM	0.47
7/6/2015	12:15:00 PM	0.47
7/6/2015	12:30:00 PM	0.47
7/6/2015	12:45:00 PM	0.47
7/6/2015	1:00:00 PM	0.47
7/6/2015	1:15:00 PM	0.47
7/6/2015	1:30:00 PM	0.47
7/6/2015	1:45:00 PM	0.46
7/6/2015	2:00:00 PM	0.46
7/6/2015	2:15:00 PM	0.46
7/6/2015	2:30:00 PM	0.46
7/6/2015	2:45:00 PM	0.46
7/6/2015	3:00:00 PM	0.45
7/6/2015	3:15:00 PM	0.45
7/6/2015	3:30:00 PM	0.45
7/6/2015	3:45:00 PM	0.45
7/6/2015	4:00:00 PM	0.45
7/6/2015	4:15:00 PM	0.45
7/6/2015	4:30:00 PM	0.45
7/6/2015	4:45:00 PM	0.45
7/6/2015	5:00:00 PM	0.45
7/6/2015	5:15:00 PM	0.45
7/6/2015	5:30:00 PM	0.45
7/6/2015	5:45:00 PM	0.45

Goose Lake Return Gage

DATE	TIME	GAGE
7/6/2015	6:00:00 PM	0.45
7/6/2015	6:15:00 PM	0.45
7/6/2015	6:30:00 PM	0.45
7/6/2015	6:45:00 PM	0.45
7/6/2015	7:00:00 PM	0.45
7/6/2015	7:15:00 PM	0.45
7/6/2015	7:30:00 PM	0.45
7/6/2015	7:45:00 PM	0.45
7/6/2015	8:00:00 PM	0.45
7/6/2015	8:15:00 PM	0.45
7/6/2015	8:30:00 PM	0.45
7/6/2015	8:45:00 PM	0.45
7/6/2015	9:00:00 PM	0.45
7/6/2015	9:15:00 PM	0.46
7/6/2015	9:30:00 PM	0.46
7/6/2015	9:45:00 PM	0.45
7/6/2015	10:00:00 PM	0.45
7/6/2015	10:15:00 PM	0.45
7/6/2015	10:30:00 PM	0.45
7/6/2015	10:45:00 PM	0.45
7/6/2015	11:00:00 PM	0.45
7/6/2015	11:15:00 PM	0.45
7/6/2015	11:30:00 PM	0.45
7/6/2015	11:45:00 PM	0.45
7/7/2015	12:00:00 AM	0.45
7/7/2015	12:15:00 AM	0.45
7/7/2015	12:30:00 AM	0.45
7/7/2015	12:45:00 AM	0.46
7/7/2015	1:00:00 AM	0.46
7/7/2015	1:15:00 AM	0.46
7/7/2015	1:30:00 AM	0.46
7/7/2015	1:45:00 AM	0.46
7/7/2015	2:00:00 AM	0.46
7/7/2015	2:15:00 AM	0.46
7/7/2015	2:30:00 AM	0.46
7/7/2015	2:45:00 AM	0.46
7/7/2015	3:00:00 AM	0.46
7/7/2015	3:15:00 AM	0.46
7/7/2015	3:30:00 AM	0.46
7/7/2015	3:45:00 AM	0.46
7/7/2015	4:00:00 AM	0.47
7/7/2015	4:15:00 AM	0.47
7/7/2015	4:30:00 AM	0.47
7/7/2015	4:45:00 AM	0.47
7/7/2015	5:00:00 AM	0.47
7/7/2015	5:15:00 AM	0.47

Goose Lake Return Gage

DATE	TIME	GAGE
7/7/2015	5:30:00 AM	0.47
7/7/2015	5:45:00 AM	0.47
7/7/2015	6:00:00 AM	0.47
7/7/2015	6:15:00 AM	0.47
7/7/2015	6:30:00 AM	0.47
7/7/2015	6:45:00 AM	0.47
7/7/2015	7:00:00 AM	0.47
7/7/2015	7:15:00 AM	0.47
7/7/2015	7:30:00 AM	0.47
7/7/2015	7:45:00 AM	0.47
7/7/2015	8:00:00 AM	0.47
7/7/2015	8:15:00 AM	0.47
7/7/2015	8:30:00 AM	0.47
7/7/2015	8:45:00 AM	0.47
7/7/2015	9:00:00 AM	0.46
7/7/2015	9:15:00 AM	0.47
7/7/2015	9:30:00 AM	0.47
7/7/2015	9:45:00 AM	0.47
7/7/2015	10:00:00 AM	0.47
7/7/2015	10:15:00 AM	0.47
7/7/2015	10:30:00 AM	0.47
7/7/2015	10:45:00 AM	0.46
7/7/2015	11:00:00 AM	0.46
7/7/2015	11:15:00 AM	0.46
7/7/2015	11:30:00 AM	0.46
7/7/2015	11:45:00 AM	0.46
7/7/2015	12:00:00 PM	0.46
7/7/2015	12:15:00 PM	0.46
7/7/2015	12:30:00 PM	0.46
7/7/2015	12:45:00 PM	0.46
7/7/2015	1:00:00 PM	0.46
7/7/2015	1:15:00 PM	0.45
7/7/2015	1:30:00 PM	0.45
7/7/2015	1:45:00 PM	0.45
7/7/2015	2:00:00 PM	0.45
7/7/2015	2:15:00 PM	0.45
7/7/2015	2:30:00 PM	0.45
7/7/2015	2:45:00 PM	0.45
7/7/2015	3:00:00 PM	0.45
7/7/2015	3:15:00 PM	0.45
7/7/2015	3:30:00 PM	0.45
7/7/2015	3:45:00 PM	0.44
7/7/2015	4:00:00 PM	0.45
7/7/2015	4:15:00 PM	0.44
7/7/2015	4:30:00 PM	0.44
7/7/2015	4:45:00 PM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
7/7/2015	5:00:00 PM	0.43
7/7/2015	5:15:00 PM	0.43
7/7/2015	5:30:00 PM	0.43
7/7/2015	5:45:00 PM	0.43
7/7/2015	6:00:00 PM	0.43
7/7/2015	6:15:00 PM	0.43
7/7/2015	6:30:00 PM	0.43
7/7/2015	6:45:00 PM	0.43
7/7/2015	7:00:00 PM	0.43
7/7/2015	7:15:00 PM	0.43
7/7/2015	7:30:00 PM	0.43
7/7/2015	7:45:00 PM	0.43
7/7/2015	8:00:00 PM	0.43
7/7/2015	8:15:00 PM	0.43
7/7/2015	8:30:00 PM	0.43
7/7/2015	8:45:00 PM	0.43
7/7/2015	9:00:00 PM	0.43
7/7/2015	9:15:00 PM	0.43
7/7/2015	9:30:00 PM	0.43
7/7/2015	9:45:00 PM	0.43
7/7/2015	10:00:00 PM	0.43
7/7/2015	10:15:00 PM	0.43
7/7/2015	10:30:00 PM	0.44
7/7/2015	10:45:00 PM	0.43
7/7/2015	11:00:00 PM	0.44
7/7/2015	11:15:00 PM	0.43
7/7/2015	11:30:00 PM	0.43
7/7/2015	11:45:00 PM	0.44
7/8/2015	12:00:00 AM	0.44
7/8/2015	12:15:00 AM	0.44
7/8/2015	12:30:00 AM	0.44
7/8/2015	12:45:00 AM	0.44
7/8/2015	1:00:00 AM	0.44
7/8/2015	1:15:00 AM	0.44
7/8/2015	1:30:00 AM	0.44
7/8/2015	1:45:00 AM	0.44
7/8/2015	2:00:00 AM	0.45
7/8/2015	2:15:00 AM	0.45
7/8/2015	2:30:00 AM	0.45
7/8/2015	2:45:00 AM	0.45
7/8/2015	3:00:00 AM	0.44
7/8/2015	3:15:00 AM	0.45
7/8/2015	3:30:00 AM	0.45
7/8/2015	3:45:00 AM	0.45
7/8/2015	4:00:00 AM	0.45
7/8/2015	4:15:00 AM	0.45

Goose Lake Return Gage

DATE	TIME	GAGE
7/8/2015	4:30:00 AM	0.45
7/8/2015	4:45:00 AM	0.45
7/8/2015	5:00:00 AM	0.45
7/8/2015	5:15:00 AM	0.45
7/8/2015	5:30:00 AM	0.45
7/8/2015	5:45:00 AM	0.45
7/8/2015	6:00:00 AM	0.45
7/8/2015	6:15:00 AM	0.45
7/8/2015	6:30:00 AM	0.45
7/8/2015	6:45:00 AM	0.45
7/8/2015	7:00:00 AM	0.45
7/8/2015	7:15:00 AM	0.45
7/8/2015	7:30:00 AM	0.45
7/8/2015	7:45:00 AM	0.45
7/8/2015	8:00:00 AM	0.45
7/8/2015	8:15:00 AM	0.45
7/8/2015	8:30:00 AM	0.45
7/8/2015	8:45:00 AM	0.45
7/8/2015	9:00:00 AM	0.45
7/8/2015	9:15:00 AM	0.45
7/8/2015	9:30:00 AM	0.45
7/8/2015	9:45:00 AM	0.45
7/8/2015	10:00:00 AM	0.45
7/8/2015	10:15:00 AM	0.45
7/8/2015	10:30:00 AM	0.45
7/8/2015	10:45:00 AM	0.45
7/8/2015	11:00:00 AM	0.45
7/8/2015	11:15:00 AM	0.45
7/8/2015	11:30:00 AM	0.44
7/8/2015	11:45:00 AM	0.44
7/8/2015	12:00:00 PM	0.43
7/8/2015	12:15:00 PM	0.44
7/8/2015	12:30:00 PM	0.44
7/8/2015	12:45:00 PM	0.44
7/8/2015	1:00:00 PM	0.44
7/8/2015	1:15:00 PM	0.43
7/8/2015	1:30:00 PM	0.43
7/8/2015	1:45:00 PM	0.43
7/8/2015	2:00:00 PM	0.43
7/8/2015	2:15:00 PM	0.43
7/8/2015	2:30:00 PM	0.43
7/8/2015	2:45:00 PM	0.43
7/8/2015	3:00:00 PM	0.43
7/8/2015	3:15:00 PM	0.42
7/8/2015	3:30:00 PM	0.43
7/8/2015	3:45:00 PM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
7/8/2015	4:00:00 PM	0.42
7/8/2015	4:15:00 PM	0.42
7/8/2015	4:30:00 PM	0.42
7/8/2015	4:45:00 PM	0.41
7/8/2015	5:00:00 PM	0.41
7/8/2015	5:15:00 PM	0.42
7/8/2015	5:30:00 PM	0.42
7/8/2015	5:45:00 PM	0.42
7/8/2015	6:00:00 PM	0.42
7/8/2015	6:15:00 PM	0.42
7/8/2015	6:30:00 PM	0.42
7/8/2015	6:45:00 PM	0.42
7/8/2015	7:00:00 PM	0.41
7/8/2015	7:15:00 PM	0.41
7/8/2015	7:30:00 PM	0.41
7/8/2015	7:45:00 PM	0.41
7/8/2015	8:00:00 PM	0.41
7/8/2015	8:15:00 PM	0.41
7/8/2015	8:30:00 PM	0.41
7/8/2015	8:45:00 PM	0.41
7/8/2015	9:00:00 PM	0.41
7/8/2015	9:15:00 PM	0.41
7/8/2015	9:30:00 PM	0.41
7/8/2015	9:45:00 PM	0.41
7/8/2015	10:00:00 PM	0.41
7/8/2015	10:15:00 PM	0.41
7/8/2015	10:30:00 PM	0.41
7/8/2015	10:45:00 PM	0.41
7/8/2015	11:00:00 PM	0.41
7/8/2015	11:15:00 PM	0.41
7/8/2015	11:30:00 PM	0.41
7/8/2015	11:45:00 PM	0.41
7/9/2015	12:00:00 AM	0.41
7/9/2015	12:15:00 AM	0.42
7/9/2015	12:30:00 AM	0.41
7/9/2015	12:45:00 AM	0.42
7/9/2015	1:00:00 AM	0.41
7/9/2015	1:15:00 AM	0.41
7/9/2015	1:30:00 AM	0.41
7/9/2015	1:45:00 AM	0.42
7/9/2015	2:00:00 AM	0.42
7/9/2015	2:15:00 AM	0.43
7/9/2015	2:30:00 AM	0.42
7/9/2015	2:45:00 AM	0.42
7/9/2015	3:00:00 AM	0.42
7/9/2015	3:15:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
7/9/2015	3:30:00 AM	0.42
7/9/2015	3:45:00 AM	0.42
7/9/2015	4:00:00 AM	0.42
7/9/2015	4:15:00 AM	0.42
7/9/2015	4:30:00 AM	0.42
7/9/2015	4:45:00 AM	0.42
7/9/2015	5:00:00 AM	0.42
7/9/2015	5:15:00 AM	0.42
7/9/2015	5:30:00 AM	0.42
7/9/2015	5:45:00 AM	0.41
7/9/2015	6:00:00 AM	0.41
7/9/2015	6:15:00 AM	0.42
7/9/2015	6:30:00 AM	0.42
7/9/2015	6:45:00 AM	0.41
7/9/2015	7:00:00 AM	0.42
7/9/2015	7:15:00 AM	0.41
7/9/2015	7:30:00 AM	0.41
7/9/2015	7:45:00 AM	0.42
7/9/2015	8:00:00 AM	0.42
7/9/2015	8:15:00 AM	0.42
7/9/2015	8:30:00 AM	0.42
7/9/2015	8:45:00 AM	0.42
7/9/2015	9:00:00 AM	0.42
7/9/2015	9:15:00 AM	0.42
7/9/2015	9:30:00 AM	0.42
7/9/2015	9:45:00 AM	0.42
7/9/2015	10:00:00 AM	0.42
7/9/2015	10:15:00 AM	0.42
7/9/2015	10:30:00 AM	0.42
7/9/2015	10:45:00 AM	0.42
7/9/2015	11:00:00 AM	0.41
7/9/2015	11:15:00 AM	0.41
7/9/2015	11:30:00 AM	0.41
7/9/2015	11:45:00 AM	0.41
7/9/2015	12:00:00 PM	0.41
7/9/2015	12:15:00 PM	0.41
7/9/2015	12:30:00 PM	0.41
7/9/2015	12:45:00 PM	0.41
7/9/2015	1:00:00 PM	0.41
7/9/2015	1:15:00 PM	0.41
7/9/2015	1:30:00 PM	0.41
7/9/2015	1:45:00 PM	0.41
7/9/2015	2:00:00 PM	0.41
7/9/2015	2:15:00 PM	0.41
7/9/2015	2:30:00 PM	0.41
7/9/2015	2:45:00 PM	0.41

Goose Lake Return Gage

DATE	TIME	GAGE
7/9/2015	3:00:00 PM	0.41
7/9/2015	3:15:00 PM	0.41
7/9/2015	3:30:00 PM	0.41
7/9/2015	3:45:00 PM	0.41
7/9/2015	4:00:00 PM	0.41
7/9/2015	4:15:00 PM	0.41
7/9/2015	4:30:00 PM	0.41
7/9/2015	4:45:00 PM	0.41
7/9/2015	5:00:00 PM	0.41
7/9/2015	5:15:00 PM	0.41
7/9/2015	5:30:00 PM	0.41
7/9/2015	5:45:00 PM	0.41
7/9/2015	6:00:00 PM	0.41
7/9/2015	6:15:00 PM	0.41
7/9/2015	6:30:00 PM	0.41
7/9/2015	6:45:00 PM	0.41
7/9/2015	7:00:00 PM	0.41
7/9/2015	7:15:00 PM	0.41
7/9/2015	7:30:00 PM	0.41
7/9/2015	7:45:00 PM	0.41
7/9/2015	8:00:00 PM	0.41
7/9/2015	8:15:00 PM	0.41
7/9/2015	8:30:00 PM	0.41
7/9/2015	8:45:00 PM	0.41
7/9/2015	9:00:00 PM	0.41
7/9/2015	9:15:00 PM	0.41
7/9/2015	9:30:00 PM	0.41
7/9/2015	9:45:00 PM	0.41
7/9/2015	10:00:00 PM	0.41
7/9/2015	10:15:00 PM	0.41
7/9/2015	10:30:00 PM	0.41
7/9/2015	10:45:00 PM	0.41
7/9/2015	11:00:00 PM	0.41
7/9/2015	11:15:00 PM	0.41
7/9/2015	11:30:00 PM	0.41
7/9/2015	11:45:00 PM	0.41
7/10/2015	12:00:00 AM	0.41
7/10/2015	12:15:00 AM	0.41
7/10/2015	12:30:00 AM	0.41
7/10/2015	12:45:00 AM	0.41
7/10/2015	1:00:00 AM	0.41
7/10/2015	1:15:00 AM	0.41
7/10/2015	1:30:00 AM	0.41
7/10/2015	1:45:00 AM	0.41
7/10/2015	2:00:00 AM	0.41
7/10/2015	2:15:00 AM	0.41

Goose Lake Return Gage

DATE	TIME	GAGE
7/10/2015	2:30:00 AM	0.41
7/10/2015	2:45:00 AM	0.42
7/10/2015	3:00:00 AM	0.42
7/10/2015	3:15:00 AM	0.42
7/10/2015	3:30:00 AM	0.42
7/10/2015	3:45:00 AM	0.42
7/10/2015	4:00:00 AM	0.42
7/10/2015	4:15:00 AM	0.42
7/10/2015	4:30:00 AM	0.42
7/10/2015	4:45:00 AM	0.42
7/10/2015	5:00:00 AM	0.42
7/10/2015	5:15:00 AM	0.42
7/10/2015	5:30:00 AM	0.42
7/10/2015	5:45:00 AM	0.42
7/10/2015	6:00:00 AM	0.42
7/10/2015	6:15:00 AM	0.42
7/10/2015	6:30:00 AM	0.42
7/10/2015	6:45:00 AM	0.42
7/10/2015	7:00:00 AM	0.42
7/10/2015	7:15:00 AM	0.42
7/10/2015	7:30:00 AM	0.42
7/10/2015	7:45:00 AM	0.42
7/10/2015	8:00:00 AM	0.43
7/10/2015	8:15:00 AM	0.43
7/10/2015	8:30:00 AM	0.43
7/10/2015	8:45:00 AM	0.43
7/10/2015	9:00:00 AM	0.43
7/10/2015	9:15:00 AM	0.43
7/10/2015	9:30:00 AM	0.42
7/10/2015	9:45:00 AM	0.43
7/10/2015	10:00:00 AM	0.43
7/10/2015	10:15:00 AM	0.43
7/10/2015	10:30:00 AM	0.43
7/10/2015	10:45:00 AM	0.43
7/10/2015	11:00:00 AM	0.43
7/10/2015	11:15:00 AM	0.43
7/10/2015	11:30:00 AM	0.43
7/10/2015	11:45:00 AM	0.43
7/10/2015	12:00:00 PM	0.43
7/10/2015	12:15:00 PM	0.42
7/10/2015	12:30:00 PM	0.43
7/10/2015	12:45:00 PM	0.42
7/10/2015	1:00:00 PM	0.42
7/10/2015	1:15:00 PM	0.42
7/10/2015	1:30:00 PM	0.43
7/10/2015	1:45:00 PM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
7/10/2015	2:00:00 PM	0.42
7/10/2015	2:15:00 PM	0.42
7/10/2015	2:30:00 PM	0.41
7/10/2015	2:45:00 PM	0.42
7/10/2015	3:00:00 PM	0.42
7/10/2015	3:15:00 PM	0.42
7/10/2015	3:30:00 PM	0.42
7/10/2015	3:45:00 PM	0.42
7/10/2015	4:00:00 PM	0.42
7/10/2015	4:15:00 PM	0.42
7/10/2015	4:30:00 PM	0.42
7/10/2015	4:45:00 PM	0.42
7/10/2015	5:00:00 PM	0.42
7/10/2015	5:15:00 PM	0.42
7/10/2015	5:30:00 PM	0.43
7/10/2015	5:45:00 PM	0.43
7/10/2015	6:00:00 PM	0.43
7/10/2015	6:15:00 PM	0.43
7/10/2015	6:30:00 PM	0.43
7/10/2015	6:45:00 PM	0.43
7/10/2015	7:00:00 PM	0.43
7/10/2015	7:15:00 PM	0.43
7/10/2015	7:30:00 PM	0.43
7/10/2015	7:45:00 PM	0.43
7/10/2015	8:00:00 PM	0.43
7/10/2015	8:15:00 PM	0.43
7/10/2015	8:30:00 PM	0.43
7/10/2015	8:45:00 PM	0.43
7/10/2015	9:00:00 PM	0.43
7/10/2015	9:15:00 PM	0.43
7/10/2015	9:30:00 PM	0.43
7/10/2015	9:45:00 PM	0.43
7/10/2015	10:00:00 PM	0.43
7/10/2015	10:15:00 PM	0.43
7/10/2015	10:30:00 PM	0.43
7/10/2015	10:45:00 PM	0.44
7/10/2015	11:00:00 PM	0.44
7/10/2015	11:15:00 PM	0.44
7/10/2015	11:30:00 PM	0.44
7/10/2015	11:45:00 PM	0.45
7/11/2015	12:00:00 AM	0.45
7/11/2015	12:15:00 AM	0.45
7/11/2015	12:30:00 AM	0.45
7/11/2015	12:45:00 AM	0.45
7/11/2015	1:00:00 AM	0.45
7/11/2015	1:15:00 AM	0.45

Goose Lake Return Gage

DATE	TIME	GAGE
7/11/2015	1:30:00 AM	0.45
7/11/2015	1:45:00 AM	0.45
7/11/2015	2:00:00 AM	0.45
7/11/2015	2:15:00 AM	0.45
7/11/2015	2:30:00 AM	0.45
7/11/2015	2:45:00 AM	0.45
7/11/2015	3:00:00 AM	0.45
7/11/2015	3:15:00 AM	0.45
7/11/2015	3:30:00 AM	0.45
7/11/2015	3:45:00 AM	0.45
7/11/2015	4:00:00 AM	0.45
7/11/2015	4:15:00 AM	0.45
7/11/2015	4:30:00 AM	0.45
7/11/2015	4:45:00 AM	0.45
7/11/2015	5:00:00 AM	0.45
7/11/2015	5:15:00 AM	0.45
7/11/2015	5:30:00 AM	0.45
7/11/2015	5:45:00 AM	0.45
7/11/2015	6:00:00 AM	0.45
7/11/2015	6:15:00 AM	0.45
7/11/2015	6:30:00 AM	0.45
7/11/2015	6:45:00 AM	0.45
7/11/2015	7:00:00 AM	0.45
7/11/2015	7:15:00 AM	0.45
7/11/2015	7:30:00 AM	0.46
7/11/2015	7:45:00 AM	0.46
7/11/2015	8:00:00 AM	0.47
7/11/2015	8:15:00 AM	0.47
7/11/2015	8:30:00 AM	0.47
7/11/2015	8:45:00 AM	0.47
7/11/2015	9:00:00 AM	0.47
7/11/2015	9:15:00 AM	0.47
7/11/2015	9:30:00 AM	0.47
7/11/2015	9:45:00 AM	0.47
7/11/2015	10:00:00 AM	0.47
7/11/2015	10:15:00 AM	0.47
7/11/2015	10:30:00 AM	0.47
7/11/2015	10:45:00 AM	0.47
7/11/2015	11:00:00 AM	0.47
7/11/2015	11:15:00 AM	0.47
7/11/2015	11:30:00 AM	0.47
7/11/2015	11:45:00 AM	0.47
7/11/2015	12:00:00 PM	0.47
7/11/2015	12:15:00 PM	0.47
7/11/2015	12:30:00 PM	0.47
7/11/2015	12:45:00 PM	0.47

Goose Lake Return Gage

DATE	TIME	GAGE
7/11/2015	1:00:00 PM	0.47
7/11/2015	1:15:00 PM	0.47
7/11/2015	1:30:00 PM	0.47
7/11/2015	1:45:00 PM	0.46
7/11/2015	2:00:00 PM	0.47
7/11/2015	2:15:00 PM	0.46
7/11/2015	2:30:00 PM	0.47
7/11/2015	2:45:00 PM	0.46
7/11/2015	3:00:00 PM	0.46
7/11/2015	3:15:00 PM	0.46
7/11/2015	3:30:00 PM	0.46
7/11/2015	3:45:00 PM	0.46
7/11/2015	4:00:00 PM	0.46
7/11/2015	4:15:00 PM	0.46
7/11/2015	4:30:00 PM	0.46
7/11/2015	4:45:00 PM	0.46
7/11/2015	5:00:00 PM	0.46
7/11/2015	5:15:00 PM	0.46
7/11/2015	5:30:00 PM	0.45
7/11/2015	5:45:00 PM	0.45
7/11/2015	6:00:00 PM	0.45
7/11/2015	6:15:00 PM	0.45
7/11/2015	6:30:00 PM	0.45
7/11/2015	6:45:00 PM	0.45
7/11/2015	7:00:00 PM	0.45
7/11/2015	7:15:00 PM	0.45
7/11/2015	7:30:00 PM	0.46
7/11/2015	7:45:00 PM	0.45
7/11/2015	8:00:00 PM	0.45
7/11/2015	8:15:00 PM	0.46
7/11/2015	8:30:00 PM	0.46
7/11/2015	8:45:00 PM	0.46
7/11/2015	9:00:00 PM	0.46
7/11/2015	9:15:00 PM	0.45
7/11/2015	9:30:00 PM	0.46
7/11/2015	9:45:00 PM	0.46
7/11/2015	10:00:00 PM	0.46
7/11/2015	10:15:00 PM	0.46
7/11/2015	10:30:00 PM	0.46
7/11/2015	10:45:00 PM	0.46
7/11/2015	11:00:00 PM	0.46
7/11/2015	11:15:00 PM	0.46
7/11/2015	11:30:00 PM	0.46
7/11/2015	11:45:00 PM	0.46
7/12/2015	12:00:00 AM	0.47
7/12/2015	12:15:00 AM	0.47

Goose Lake Return Gage

DATE	TIME	GAGE
7/12/2015	12:30:00 AM	0.47
7/12/2015	12:45:00 AM	0.47
7/12/2015	1:00:00 AM	0.47
7/12/2015	1:15:00 AM	0.47
7/12/2015	1:30:00 AM	0.47
7/12/2015	1:45:00 AM	0.47
7/12/2015	2:00:00 AM	0.47
7/12/2015	2:15:00 AM	0.47
7/12/2015	2:30:00 AM	0.47
7/12/2015	2:45:00 AM	0.47
7/12/2015	3:00:00 AM	0.47
7/12/2015	3:15:00 AM	0.47
7/12/2015	3:30:00 AM	0.47
7/12/2015	3:45:00 AM	0.47
7/12/2015	4:00:00 AM	0.47
7/12/2015	4:15:00 AM	0.47
7/12/2015	4:30:00 AM	0.47
7/12/2015	4:45:00 AM	0.47
7/12/2015	5:00:00 AM	0.47
7/12/2015	5:15:00 AM	0.47
7/12/2015	5:30:00 AM	0.47
7/12/2015	5:45:00 AM	0.47
7/12/2015	6:00:00 AM	0.47
7/12/2015	6:15:00 AM	0.47
7/12/2015	6:30:00 AM	0.47
7/12/2015	6:45:00 AM	0.47
7/12/2015	7:00:00 AM	0.47
7/12/2015	7:15:00 AM	0.47
7/12/2015	7:30:00 AM	0.47
7/12/2015	7:45:00 AM	0.47
7/12/2015	8:00:00 AM	0.47
7/12/2015	8:15:00 AM	0.47
7/12/2015	8:30:00 AM	0.47
7/12/2015	8:45:00 AM	0.47
7/12/2015	9:00:00 AM	0.47
7/12/2015	9:15:00 AM	0.47
7/12/2015	9:30:00 AM	0.47
7/12/2015	9:45:00 AM	0.47
7/12/2015	10:00:00 AM	0.47
7/12/2015	10:15:00 AM	0.47
7/12/2015	10:30:00 AM	0.48
7/12/2015	10:45:00 AM	0.47
7/12/2015	11:00:00 AM	0.47
7/12/2015	11:15:00 AM	0.47
7/12/2015	11:30:00 AM	0.47
7/12/2015	11:45:00 AM	0.47

Goose Lake Return Gage

DATE	TIME	GAGE
7/12/2015	12:00:00 PM	0.47
7/12/2015	12:15:00 PM	0.47
7/12/2015	12:30:00 PM	0.47
7/12/2015	12:45:00 PM	0.47
7/12/2015	1:00:00 PM	0.47
7/12/2015	1:15:00 PM	0.47
7/12/2015	1:30:00 PM	0.47
7/12/2015	1:45:00 PM	0.47
7/12/2015	2:00:00 PM	0.47
7/12/2015	2:15:00 PM	0.47
7/12/2015	2:30:00 PM	0.47
7/12/2015	2:45:00 PM	0.47
7/12/2015	3:00:00 PM	0.47
7/12/2015	3:15:00 PM	0.47
7/12/2015	3:30:00 PM	0.47
7/12/2015	3:45:00 PM	0.47
7/12/2015	4:00:00 PM	0.46
7/12/2015	4:15:00 PM	0.46
7/12/2015	4:30:00 PM	0.46
7/12/2015	4:45:00 PM	0.46
7/12/2015	5:00:00 PM	0.46
7/12/2015	5:15:00 PM	0.45
7/12/2015	5:30:00 PM	0.45
7/12/2015	5:45:00 PM	0.45
7/12/2015	6:00:00 PM	0.46
7/12/2015	6:15:00 PM	0.45
7/12/2015	6:30:00 PM	0.45
7/12/2015	6:45:00 PM	0.45
7/12/2015	7:00:00 PM	0.45
7/12/2015	7:15:00 PM	0.45
7/12/2015	7:30:00 PM	0.45
7/12/2015	7:45:00 PM	0.45
7/12/2015	8:00:00 PM	0.45
7/12/2015	8:15:00 PM	0.45
7/12/2015	8:30:00 PM	0.45
7/12/2015	8:45:00 PM	0.45
7/12/2015	9:00:00 PM	0.45
7/12/2015	9:15:00 PM	0.45
7/12/2015	9:30:00 PM	0.45
7/12/2015	9:45:00 PM	0.45
7/12/2015	10:00:00 PM	0.45
7/12/2015	10:15:00 PM	0.46
7/12/2015	10:30:00 PM	0.46
7/12/2015	10:45:00 PM	0.46
7/12/2015	11:00:00 PM	0.46
7/12/2015	11:15:00 PM	0.45

Goose Lake Return Gage

DATE	TIME	GAGE
7/12/2015	11:30:00 PM	0.45
7/12/2015	11:45:00 PM	0.45
7/13/2015	12:00:00 AM	0.45
7/13/2015	12:15:00 AM	0.45
7/13/2015	12:30:00 AM	0.45
7/13/2015	12:45:00 AM	0.45
7/13/2015	1:00:00 AM	0.45
7/13/2015	1:15:00 AM	0.45
7/13/2015	1:30:00 AM	0.45
7/13/2015	1:45:00 AM	0.45
7/13/2015	2:00:00 AM	0.45
7/13/2015	2:15:00 AM	0.45
7/13/2015	2:30:00 AM	0.45
7/13/2015	2:45:00 AM	0.46
7/13/2015	3:00:00 AM	0.46
7/13/2015	3:15:00 AM	0.46
7/13/2015	3:30:00 AM	0.46
7/13/2015	3:45:00 AM	0.46
7/13/2015	4:00:00 AM	0.46
7/13/2015	4:15:00 AM	0.46
7/13/2015	4:30:00 AM	0.47
7/13/2015	4:45:00 AM	0.47
7/13/2015	5:00:00 AM	0.47
7/13/2015	5:15:00 AM	0.47
7/13/2015	5:30:00 AM	0.47
7/13/2015	5:45:00 AM	0.47
7/13/2015	6:00:00 AM	0.47
7/13/2015	6:15:00 AM	0.47
7/13/2015	6:30:00 AM	0.47
7/13/2015	6:45:00 AM	0.47
7/13/2015	7:00:00 AM	0.47
7/13/2015	7:15:00 AM	0.47
7/13/2015	7:30:00 AM	0.47
7/13/2015	7:45:00 AM	0.47
7/13/2015	8:00:00 AM	0.47
7/13/2015	8:15:00 AM	0.46
7/13/2015	8:30:00 AM	0.47
7/13/2015	8:45:00 AM	0.46
7/13/2015	9:00:00 AM	0.47
7/13/2015	9:15:00 AM	0.47
7/13/2015	9:30:00 AM	0.47
7/13/2015	9:45:00 AM	0.47
7/13/2015	10:00:00 AM	0.47
7/13/2015	10:15:00 AM	0.47
7/13/2015	10:30:00 AM	0.47
7/13/2015	10:45:00 AM	0.47

Goose Lake Return Gage

DATE	TIME	GAGE
7/13/2015	11:00:00 AM	0.46
7/13/2015	11:15:00 AM	0.47
7/13/2015	11:30:00 AM	0.47
7/13/2015	11:45:00 AM	0.47
7/13/2015	12:00:00 PM	0.47
7/13/2015	12:15:00 PM	0.46
7/13/2015	12:30:00 PM	0.46
7/13/2015	12:45:00 PM	0.46
7/13/2015	1:00:00 PM	0.46
7/13/2015	1:15:00 PM	0.46
7/13/2015	1:30:00 PM	0.46
7/13/2015	1:45:00 PM	0.45
7/13/2015	2:00:00 PM	0.45
7/13/2015	2:15:00 PM	0.45
7/13/2015	2:30:00 PM	0.45
7/13/2015	2:45:00 PM	0.45
7/13/2015	3:00:00 PM	0.45
7/13/2015	3:15:00 PM	0.45
7/13/2015	3:30:00 PM	0.45
7/13/2015	3:45:00 PM	0.45
7/13/2015	4:00:00 PM	0.45
7/13/2015	4:15:00 PM	0.45
7/13/2015	4:30:00 PM	0.45
7/13/2015	4:45:00 PM	0.44
7/13/2015	5:00:00 PM	0.45
7/13/2015	5:15:00 PM	0.44
7/13/2015	5:30:00 PM	0.44
7/13/2015	5:45:00 PM	0.44
7/13/2015	6:00:00 PM	0.43
7/13/2015	6:15:00 PM	0.43
7/13/2015	6:30:00 PM	0.43
7/13/2015	6:45:00 PM	0.43
7/13/2015	7:00:00 PM	0.43
7/13/2015	7:15:00 PM	0.43
7/13/2015	7:30:00 PM	0.43
7/13/2015	7:45:00 PM	0.43
7/13/2015	8:00:00 PM	0.43
7/13/2015	8:15:00 PM	0.43
7/13/2015	8:30:00 PM	0.43
7/13/2015	8:45:00 PM	0.43
7/13/2015	9:00:00 PM	0.43
7/13/2015	9:15:00 PM	0.44
7/13/2015	9:30:00 PM	0.44
7/13/2015	9:45:00 PM	0.44
7/13/2015	10:00:00 PM	0.43
7/13/2015	10:15:00 PM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
7/13/2015	10:30:00 PM	0.43
7/13/2015	10:45:00 PM	0.43
7/13/2015	11:00:00 PM	0.43
7/13/2015	11:15:00 PM	0.43
7/13/2015	11:30:00 PM	0.43
7/13/2015	11:45:00 PM	0.43
7/14/2015	12:00:00 AM	0.43
7/14/2015	12:15:00 AM	0.43
7/14/2015	12:30:00 AM	0.43
7/14/2015	12:45:00 AM	0.43
7/14/2015	1:00:00 AM	0.44
7/14/2015	1:15:00 AM	0.44
7/14/2015	1:30:00 AM	0.44
7/14/2015	1:45:00 AM	0.44
7/14/2015	2:00:00 AM	0.44
7/14/2015	2:15:00 AM	0.44
7/14/2015	2:30:00 AM	0.44
7/14/2015	2:45:00 AM	0.44
7/14/2015	3:00:00 AM	0.44
7/14/2015	3:15:00 AM	0.44
7/14/2015	3:30:00 AM	0.44
7/14/2015	3:45:00 AM	0.44
7/14/2015	4:00:00 AM	0.44
7/14/2015	4:15:00 AM	0.44
7/14/2015	4:30:00 AM	0.44
7/14/2015	4:45:00 AM	0.44
7/14/2015	5:00:00 AM	0.44
7/14/2015	5:15:00 AM	0.44
7/14/2015	5:30:00 AM	0.44
7/14/2015	5:45:00 AM	0.44
7/14/2015	6:00:00 AM	0.44
7/14/2015	6:15:00 AM	0.44
7/14/2015	6:30:00 AM	0.44
7/14/2015	6:45:00 AM	0.44
7/14/2015	7:00:00 AM	0.44
7/14/2015	7:15:00 AM	0.44
7/14/2015	7:30:00 AM	0.44
7/14/2015	7:45:00 AM	0.45
7/14/2015	8:00:00 AM	0.45
7/14/2015	8:15:00 AM	0.45
7/14/2015	8:30:00 AM	0.45
7/14/2015	8:45:00 AM	0.45
7/14/2015	9:00:00 AM	0.45
7/14/2015	9:15:00 AM	0.45
7/14/2015	9:30:00 AM	0.45
7/14/2015	9:45:00 AM	0.45

Goose Lake Return Gage

DATE	TIME	GAGE
7/14/2015	10:00:00 AM	0.45
7/14/2015	10:15:00 AM	0.45
7/14/2015	10:30:00 AM	0.45
7/14/2015	10:45:00 AM	0.45
7/14/2015	11:00:00 AM	0.45
7/14/2015	11:15:00 AM	0.45
7/14/2015	11:30:00 AM	0.44
7/14/2015	11:45:00 AM	0.45
7/14/2015	12:00:00 PM	0.44
7/14/2015	12:15:00 PM	0.44
7/14/2015	12:30:00 PM	0.45
7/14/2015	12:45:00 PM	0.44
7/14/2015	1:00:00 PM	0.44
7/14/2015	1:15:00 PM	0.43
7/14/2015	1:30:00 PM	0.43
7/14/2015	1:45:00 PM	0.43
7/14/2015	2:00:00 PM	0.43
7/14/2015	2:15:00 PM	0.43
7/14/2015	2:30:00 PM	0.43
7/14/2015	2:45:00 PM	0.43
7/14/2015	3:00:00 PM	0.43
7/14/2015	3:15:00 PM	0.43
7/14/2015	3:30:00 PM	0.43
7/14/2015	3:45:00 PM	0.43
7/14/2015	4:00:00 PM	0.43
7/14/2015	4:15:00 PM	0.43
7/14/2015	4:30:00 PM	0.43
7/14/2015	4:45:00 PM	0.42
7/14/2015	5:00:00 PM	0.43
7/14/2015	5:15:00 PM	0.43
7/14/2015	5:30:00 PM	0.42
7/14/2015	5:45:00 PM	0.41
7/14/2015	6:00:00 PM	0.42
7/14/2015	6:15:00 PM	0.42
7/14/2015	6:30:00 PM	0.42
7/14/2015	6:45:00 PM	0.42
7/14/2015	7:00:00 PM	0.42
7/14/2015	7:15:00 PM	0.41
7/14/2015	7:30:00 PM	0.41
7/14/2015	7:45:00 PM	0.41
7/14/2015	8:00:00 PM	0.41
7/14/2015	8:15:00 PM	0.41
7/14/2015	8:30:00 PM	0.41
7/14/2015	8:45:00 PM	0.41
7/14/2015	9:00:00 PM	0.41
7/14/2015	9:15:00 PM	0.41

Goose Lake Return Gage

DATE	TIME	GAGE
7/14/2015	9:30:00 PM	0.42
7/14/2015	9:45:00 PM	0.42
7/14/2015	10:00:00 PM	0.42
7/14/2015	10:15:00 PM	0.42
7/14/2015	10:30:00 PM	0.42
7/14/2015	10:45:00 PM	0.42
7/14/2015	11:00:00 PM	0.42
7/14/2015	11:15:00 PM	0.42
7/14/2015	11:30:00 PM	0.42
7/14/2015	11:45:00 PM	0.42
7/15/2015	12:00:00 AM	0.42
7/15/2015	12:15:00 AM	0.42
7/15/2015	12:30:00 AM	0.42
7/15/2015	12:45:00 AM	0.42
7/15/2015	1:00:00 AM	0.42
7/15/2015	1:15:00 AM	0.42
7/15/2015	1:30:00 AM	0.42
7/15/2015	1:45:00 AM	0.42
7/15/2015	2:00:00 AM	0.42
7/15/2015	2:15:00 AM	0.42
7/15/2015	2:30:00 AM	0.43
7/15/2015	2:45:00 AM	0.43
7/15/2015	3:00:00 AM	0.43
7/15/2015	3:15:00 AM	0.43
7/15/2015	3:30:00 AM	0.43
7/15/2015	3:45:00 AM	0.43
7/15/2015	4:00:00 AM	0.43
7/15/2015	4:15:00 AM	0.43
7/15/2015	4:30:00 AM	0.43
7/15/2015	4:45:00 AM	0.43
7/15/2015	5:00:00 AM	0.43
7/15/2015	5:15:00 AM	0.42
7/15/2015	5:30:00 AM	0.42
7/15/2015	5:45:00 AM	0.43
7/15/2015	6:00:00 AM	0.43
7/15/2015	6:15:00 AM	0.43
7/15/2015	6:30:00 AM	0.43
7/15/2015	6:45:00 AM	0.43
7/15/2015	7:00:00 AM	0.43
7/15/2015	7:15:00 AM	0.43
7/15/2015	7:30:00 AM	0.43
7/15/2015	7:45:00 AM	0.43
7/15/2015	8:00:00 AM	0.43
7/15/2015	8:15:00 AM	0.43
7/15/2015	8:30:00 AM	0.43
7/15/2015	8:45:00 AM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
7/15/2015	9:00:00 AM	0.43
7/15/2015	9:15:00 AM	0.43
7/15/2015	9:30:00 AM	0.43
7/15/2015	9:45:00 AM	0.43
7/15/2015	10:00:00 AM	0.42
7/15/2015	10:15:00 AM	0.42
7/15/2015	10:30:00 AM	0.42
7/15/2015	10:45:00 AM	0.42
7/15/2015	11:00:00 AM	0.42
7/15/2015	11:15:00 AM	0.42
7/15/2015	11:30:00 AM	0.42
7/15/2015	11:45:00 AM	0.42
7/15/2015	12:00:00 PM	0.42
7/15/2015	12:15:00 PM	0.42
7/15/2015	12:30:00 PM	0.42
7/15/2015	12:45:00 PM	0.42
7/15/2015	1:00:00 PM	0.42
7/15/2015	1:15:00 PM	0.42
7/15/2015	1:30:00 PM	0.42
7/15/2015	1:45:00 PM	0.42
7/15/2015	2:00:00 PM	0.42
7/15/2015	2:15:00 PM	0.42
7/15/2015	2:30:00 PM	0.42
7/15/2015	2:45:00 PM	0.42
7/15/2015	3:00:00 PM	0.42
7/15/2015	3:15:00 PM	0.42
7/15/2015	3:30:00 PM	0.42
7/15/2015	3:45:00 PM	0.42
7/15/2015	4:00:00 PM	0.42
7/15/2015	4:15:00 PM	0.42
7/15/2015	4:30:00 PM	0.42
7/15/2015	4:45:00 PM	0.42
7/15/2015	5:00:00 PM	0.41
7/15/2015	5:15:00 PM	0.41
7/15/2015	5:30:00 PM	0.41
7/15/2015	5:45:00 PM	0.41
7/15/2015	6:00:00 PM	0.41
7/15/2015	6:15:00 PM	0.41
7/15/2015	6:30:00 PM	0.4
7/15/2015	6:45:00 PM	0.4
7/15/2015	7:00:00 PM	0.4
7/15/2015	7:15:00 PM	0.4
7/15/2015	7:30:00 PM	0.4
7/15/2015	7:45:00 PM	0.4
7/15/2015	8:00:00 PM	0.4
7/15/2015	8:15:00 PM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/15/2015	8:30:00 PM	0.4
7/15/2015	8:45:00 PM	0.4
7/15/2015	9:00:00 PM	0.4
7/15/2015	9:15:00 PM	0.4
7/15/2015	9:30:00 PM	0.4
7/15/2015	9:45:00 PM	0.4
7/15/2015	10:00:00 PM	0.4
7/15/2015	10:15:00 PM	0.4
7/15/2015	10:30:00 PM	0.4
7/15/2015	10:45:00 PM	0.4
7/15/2015	11:00:00 PM	0.4
7/15/2015	11:15:00 PM	0.4
7/15/2015	11:30:00 PM	0.4
7/15/2015	11:45:00 PM	0.4
7/16/2015	12:00:00 AM	0.4
7/16/2015	12:15:00 AM	0.4
7/16/2015	12:30:00 AM	0.4
7/16/2015	12:45:00 AM	0.4
7/16/2015	1:00:00 AM	0.4
7/16/2015	1:15:00 AM	0.4
7/16/2015	1:30:00 AM	0.4
7/16/2015	1:45:00 AM	0.4
7/16/2015	2:00:00 AM	0.4
7/16/2015	2:15:00 AM	0.4
7/16/2015	2:30:00 AM	0.4
7/16/2015	2:45:00 AM	0.4
7/16/2015	3:00:00 AM	0.4
7/16/2015	3:15:00 AM	0.4
7/16/2015	3:30:00 AM	0.4
7/16/2015	3:45:00 AM	0.4
7/16/2015	4:00:00 AM	0.4
7/16/2015	4:15:00 AM	0.4
7/16/2015	4:30:00 AM	0.4
7/16/2015	4:45:00 AM	0.4
7/16/2015	5:00:00 AM	0.4
7/16/2015	5:15:00 AM	0.4
7/16/2015	5:30:00 AM	0.4
7/16/2015	5:45:00 AM	0.4
7/16/2015	6:00:00 AM	0.4
7/16/2015	6:15:00 AM	0.4
7/16/2015	6:30:00 AM	0.4
7/16/2015	6:45:00 AM	0.4
7/16/2015	7:00:00 AM	0.4
7/16/2015	7:15:00 AM	0.4
7/16/2015	7:30:00 AM	0.4
7/16/2015	7:45:00 AM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/16/2015	8:00:00 AM	0.4
7/16/2015	8:15:00 AM	0.4
7/16/2015	8:30:00 AM	0.4
7/16/2015	8:45:00 AM	0.4
7/16/2015	9:00:00 AM	0.4
7/16/2015	9:15:00 AM	0.4
7/16/2015	9:30:00 AM	0.4
7/16/2015	9:45:00 AM	0.4
7/16/2015	10:00:00 AM	0.4
7/16/2015	10:15:00 AM	0.4
7/16/2015	10:30:00 AM	0.4
7/16/2015	10:45:00 AM	0.4
7/16/2015	11:00:00 AM	0.4
7/16/2015	11:15:00 AM	0.4
7/16/2015	11:30:00 AM	0.4
7/16/2015	11:45:00 AM	0.4
7/16/2015	12:00:00 PM	0.4
7/16/2015	12:15:00 PM	0.4
7/16/2015	12:30:00 PM	0.4
7/16/2015	12:45:00 PM	0.4
7/16/2015	1:00:00 PM	0.4
7/16/2015	1:15:00 PM	0.4
7/16/2015	1:30:00 PM	0.4
7/16/2015	1:45:00 PM	0.4
7/16/2015	2:00:00 PM	0.4
7/16/2015	2:15:00 PM	0.4
7/16/2015	2:30:00 PM	0.4
7/16/2015	2:45:00 PM	0.4
7/16/2015	3:00:00 PM	0.4
7/16/2015	3:15:00 PM	0.4
7/16/2015	3:30:00 PM	0.4
7/16/2015	3:45:00 PM	0.4
7/16/2015	4:00:00 PM	0.4
7/16/2015	4:15:00 PM	0.4
7/16/2015	4:30:00 PM	0.4
7/16/2015	4:45:00 PM	0.4
7/16/2015	5:00:00 PM	0.4
7/16/2015	5:15:00 PM	0.4
7/16/2015	5:30:00 PM	0.4
7/16/2015	5:45:00 PM	0.4
7/16/2015	6:00:00 PM	0.4
7/16/2015	6:15:00 PM	0.4
7/16/2015	6:30:00 PM	0.4
7/16/2015	6:45:00 PM	0.4
7/16/2015	7:00:00 PM	0.4
7/16/2015	7:15:00 PM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/16/2015	7:30:00 PM	0.4
7/16/2015	7:45:00 PM	0.4
7/16/2015	8:00:00 PM	0.4
7/16/2015	8:15:00 PM	0.4
7/16/2015	8:30:00 PM	0.4
7/16/2015	8:45:00 PM	0.4
7/16/2015	9:00:00 PM	0.4
7/16/2015	9:15:00 PM	0.4
7/16/2015	9:30:00 PM	0.4
7/16/2015	9:45:00 PM	0.4
7/16/2015	10:00:00 PM	0.4
7/16/2015	10:15:00 PM	0.4
7/16/2015	10:30:00 PM	0.4
7/16/2015	10:45:00 PM	0.4
7/16/2015	11:00:00 PM	0.4
7/16/2015	11:15:00 PM	0.4
7/16/2015	11:30:00 PM	0.4
7/16/2015	11:45:00 PM	0.4
7/17/2015	12:00:00 AM	0.4
7/17/2015	12:15:00 AM	0.4
7/17/2015	12:30:00 AM	0.4
7/17/2015	12:45:00 AM	0.4
7/17/2015	1:00:00 AM	0.4
7/17/2015	1:15:00 AM	0.4
7/17/2015	1:30:00 AM	0.4
7/17/2015	1:45:00 AM	0.4
7/17/2015	2:00:00 AM	0.4
7/17/2015	2:15:00 AM	0.4
7/17/2015	2:30:00 AM	0.4
7/17/2015	2:45:00 AM	0.4
7/17/2015	3:00:00 AM	0.4
7/17/2015	3:15:00 AM	0.4
7/17/2015	3:30:00 AM	0.4
7/17/2015	3:45:00 AM	0.4
7/17/2015	4:00:00 AM	0.4
7/17/2015	4:15:00 AM	0.4
7/17/2015	4:30:00 AM	0.4
7/17/2015	4:45:00 AM	0.4
7/17/2015	5:00:00 AM	0.4
7/17/2015	5:15:00 AM	0.4
7/17/2015	5:30:00 AM	0.4
7/17/2015	5:45:00 AM	0.4
7/17/2015	6:00:00 AM	0.4
7/17/2015	6:15:00 AM	0.4
7/17/2015	6:30:00 AM	0.4
7/17/2015	6:45:00 AM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/17/2015	7:00:00 AM	0.4
7/17/2015	7:15:00 AM	0.4
7/17/2015	7:30:00 AM	0.4
7/17/2015	7:45:00 AM	0.4
7/17/2015	8:00:00 AM	0.4
7/17/2015	8:15:00 AM	0.4
7/17/2015	8:30:00 AM	0.4
7/17/2015	8:45:00 AM	0.4
7/17/2015	9:00:00 AM	0.4
7/17/2015	9:15:00 AM	0.4
7/17/2015	9:30:00 AM	0.41
7/17/2015	9:45:00 AM	0.41
7/17/2015	10:00:00 AM	0.41
7/17/2015	10:15:00 AM	0.41
7/17/2015	10:30:00 AM	0.41
7/17/2015	10:45:00 AM	0.41
7/17/2015	11:00:00 AM	0.41
7/17/2015	11:15:00 AM	0.41
7/17/2015	11:30:00 AM	0.41
7/17/2015	11:45:00 AM	0.41
7/17/2015	12:00:00 PM	0.41
7/17/2015	12:15:00 PM	0.41
7/17/2015	12:30:00 PM	0.41
7/17/2015	12:45:00 PM	0.41
7/17/2015	1:00:00 PM	0.41
7/17/2015	1:15:00 PM	0.41
7/17/2015	1:30:00 PM	0.41
7/17/2015	1:45:00 PM	0.41
7/17/2015	2:00:00 PM	0.41
7/17/2015	2:15:00 PM	0.41
7/17/2015	2:30:00 PM	0.41
7/17/2015	2:45:00 PM	0.41
7/17/2015	3:00:00 PM	0.41
7/17/2015	3:15:00 PM	0.41
7/17/2015	3:30:00 PM	0.4
7/17/2015	3:45:00 PM	0.4
7/17/2015	4:00:00 PM	0.4
7/17/2015	4:15:00 PM	0.4
7/17/2015	4:30:00 PM	0.4
7/17/2015	4:45:00 PM	0.4
7/17/2015	5:00:00 PM	0.4
7/17/2015	5:15:00 PM	0.4
7/17/2015	5:30:00 PM	0.4
7/17/2015	5:45:00 PM	0.4
7/17/2015	6:00:00 PM	0.4
7/17/2015	6:15:00 PM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/17/2015	6:30:00 PM	0.4
7/17/2015	6:45:00 PM	0.4
7/17/2015	7:00:00 PM	0.4
7/17/2015	7:15:00 PM	0.4
7/17/2015	7:30:00 PM	0.4
7/17/2015	7:45:00 PM	0.4
7/17/2015	8:00:00 PM	0.39
7/17/2015	8:15:00 PM	0.39
7/17/2015	8:30:00 PM	0.39
7/17/2015	8:45:00 PM	0.39
7/17/2015	9:00:00 PM	0.39
7/17/2015	9:15:00 PM	0.39
7/17/2015	9:30:00 PM	0.39
7/17/2015	9:45:00 PM	0.39
7/17/2015	10:00:00 PM	0.39
7/17/2015	10:15:00 PM	0.39
7/17/2015	10:30:00 PM	0.39
7/17/2015	10:45:00 PM	0.39
7/17/2015	11:00:00 PM	0.39
7/17/2015	11:15:00 PM	0.39
7/17/2015	11:30:00 PM	0.39
7/17/2015	11:45:00 PM	0.39
7/18/2015	12:00:00 AM	0.39
7/18/2015	12:15:00 AM	0.39
7/18/2015	12:30:00 AM	0.39
7/18/2015	12:45:00 AM	0.39
7/18/2015	1:00:00 AM	0.39
7/18/2015	1:15:00 AM	0.39
7/18/2015	1:30:00 AM	0.39
7/18/2015	1:45:00 AM	0.39
7/18/2015	2:00:00 AM	0.39
7/18/2015	2:15:00 AM	0.39
7/18/2015	2:30:00 AM	0.39
7/18/2015	2:45:00 AM	0.39
7/18/2015	3:00:00 AM	0.39
7/18/2015	3:15:00 AM	0.39
7/18/2015	3:30:00 AM	0.39
7/18/2015	3:45:00 AM	0.39
7/18/2015	4:00:00 AM	0.39
7/18/2015	4:15:00 AM	0.39
7/18/2015	4:30:00 AM	0.39
7/18/2015	4:45:00 AM	0.39
7/18/2015	5:00:00 AM	0.39
7/18/2015	5:15:00 AM	0.39
7/18/2015	5:30:00 AM	0.39
7/18/2015	5:45:00 AM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/18/2015	6:00:00 AM	0.4
7/18/2015	6:15:00 AM	0.4
7/18/2015	6:30:00 AM	0.4
7/18/2015	6:45:00 AM	0.4
7/18/2015	7:00:00 AM	0.4
7/18/2015	7:15:00 AM	0.4
7/18/2015	7:30:00 AM	0.4
7/18/2015	7:45:00 AM	0.4
7/18/2015	8:00:00 AM	0.4
7/18/2015	8:15:00 AM	0.4
7/18/2015	8:30:00 AM	0.4
7/18/2015	8:45:00 AM	0.4
7/18/2015	9:00:00 AM	0.4
7/18/2015	9:15:00 AM	0.4
7/18/2015	9:30:00 AM	0.4
7/18/2015	9:45:00 AM	0.4
7/18/2015	10:00:00 AM	0.4
7/18/2015	10:15:00 AM	0.4
7/18/2015	10:30:00 AM	0.4
7/18/2015	10:45:00 AM	0.4
7/18/2015	11:00:00 AM	0.4
7/18/2015	11:15:00 AM	0.4
7/18/2015	11:30:00 AM	0.4
7/18/2015	11:45:00 AM	0.4
7/18/2015	12:00:00 PM	0.4
7/18/2015	12:15:00 PM	0.4
7/18/2015	12:30:00 PM	0.4
7/18/2015	12:45:00 PM	0.4
7/18/2015	1:00:00 PM	0.4
7/18/2015	1:15:00 PM	0.4
7/18/2015	1:30:00 PM	0.4
7/18/2015	1:45:00 PM	0.4
7/18/2015	2:00:00 PM	0.4
7/18/2015	2:15:00 PM	0.4
7/18/2015	2:30:00 PM	0.4
7/18/2015	2:45:00 PM	0.4
7/18/2015	3:00:00 PM	0.4
7/18/2015	3:15:00 PM	0.4
7/18/2015	3:30:00 PM	0.4
7/18/2015	3:45:00 PM	0.4
7/18/2015	4:00:00 PM	0.4
7/18/2015	4:15:00 PM	0.4
7/18/2015	4:30:00 PM	0.4
7/18/2015	4:45:00 PM	0.4
7/18/2015	5:00:00 PM	0.4
7/18/2015	5:15:00 PM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/18/2015	5:30:00 PM	0.4
7/18/2015	5:45:00 PM	0.39
7/18/2015	6:00:00 PM	0.39
7/18/2015	6:15:00 PM	0.39
7/18/2015	6:30:00 PM	0.39
7/18/2015	6:45:00 PM	0.39
7/18/2015	7:00:00 PM	0.39
7/18/2015	7:15:00 PM	0.39
7/18/2015	7:30:00 PM	0.39
7/18/2015	7:45:00 PM	0.39
7/18/2015	8:00:00 PM	0.39
7/18/2015	8:15:00 PM	0.39
7/18/2015	8:30:00 PM	0.39
7/18/2015	8:45:00 PM	0.39
7/18/2015	9:00:00 PM	0.39
7/18/2015	9:15:00 PM	0.39
7/18/2015	9:30:00 PM	0.39
7/18/2015	9:45:00 PM	0.39
7/18/2015	10:00:00 PM	0.39
7/18/2015	10:15:00 PM	0.39
7/18/2015	10:30:00 PM	0.39
7/18/2015	10:45:00 PM	0.39
7/18/2015	11:00:00 PM	0.39
7/18/2015	11:15:00 PM	0.39
7/18/2015	11:30:00 PM	0.39
7/18/2015	11:45:00 PM	0.39
7/19/2015	12:00:00 AM	0.39
7/19/2015	12:15:00 AM	0.39
7/19/2015	12:30:00 AM	0.39
7/19/2015	12:45:00 AM	0.39
7/19/2015	1:00:00 AM	0.39
7/19/2015	1:15:00 AM	0.39
7/19/2015	1:30:00 AM	0.39
7/19/2015	1:45:00 AM	0.39
7/19/2015	2:00:00 AM	0.39
7/19/2015	2:15:00 AM	0.39
7/19/2015	2:30:00 AM	0.39
7/19/2015	2:45:00 AM	0.39
7/19/2015	3:00:00 AM	0.39
7/19/2015	3:15:00 AM	0.39
7/19/2015	3:30:00 AM	0.39
7/19/2015	3:45:00 AM	0.39
7/19/2015	4:00:00 AM	0.39
7/19/2015	4:15:00 AM	0.39
7/19/2015	4:30:00 AM	0.39
7/19/2015	4:45:00 AM	0.39

Goose Lake Return Gage

DATE	TIME	GAGE
7/19/2015	5:00:00 AM	0.39
7/19/2015	5:15:00 AM	0.39
7/19/2015	5:30:00 AM	0.39
7/19/2015	5:45:00 AM	0.39
7/19/2015	6:00:00 AM	0.4
7/19/2015	6:15:00 AM	0.4
7/19/2015	6:30:00 AM	0.4
7/19/2015	6:45:00 AM	0.4
7/19/2015	7:00:00 AM	0.4
7/19/2015	7:15:00 AM	0.4
7/19/2015	7:30:00 AM	0.4
7/19/2015	7:45:00 AM	0.4
7/19/2015	8:00:00 AM	0.4
7/19/2015	8:15:00 AM	0.4
7/19/2015	8:30:00 AM	0.4
7/19/2015	8:45:00 AM	0.4
7/19/2015	9:00:00 AM	0.4
7/19/2015	9:15:00 AM	0.4
7/19/2015	9:30:00 AM	0.4
7/19/2015	9:45:00 AM	0.4
7/19/2015	10:00:00 AM	0.4
7/19/2015	10:15:00 AM	0.4
7/19/2015	10:30:00 AM	0.4
7/19/2015	10:45:00 AM	0.4
7/19/2015	11:00:00 AM	0.4
7/19/2015	11:15:00 AM	0.4
7/19/2015	11:30:00 AM	0.4
7/19/2015	11:45:00 AM	0.4
7/19/2015	12:00:00 PM	0.4
7/19/2015	12:15:00 PM	0.4
7/19/2015	12:30:00 PM	0.4
7/19/2015	12:45:00 PM	0.4
7/19/2015	1:00:00 PM	0.4
7/19/2015	1:15:00 PM	0.4
7/19/2015	1:30:00 PM	0.4
7/19/2015	1:45:00 PM	0.4
7/19/2015	2:00:00 PM	0.4
7/19/2015	2:15:00 PM	0.4
7/19/2015	2:30:00 PM	0.4
7/19/2015	2:45:00 PM	0.4
7/19/2015	3:00:00 PM	0.4
7/19/2015	3:15:00 PM	0.4
7/19/2015	3:30:00 PM	0.4
7/19/2015	3:45:00 PM	0.4
7/19/2015	4:00:00 PM	0.4
7/19/2015	4:15:00 PM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/19/2015	4:30:00 PM	0.4
7/19/2015	4:45:00 PM	0.4
7/19/2015	5:00:00 PM	0.4
7/19/2015	5:15:00 PM	0.4
7/19/2015	5:30:00 PM	0.4
7/19/2015	5:45:00 PM	0.4
7/19/2015	6:00:00 PM	0.4
7/19/2015	6:15:00 PM	0.4
7/19/2015	6:30:00 PM	0.4
7/19/2015	6:45:00 PM	0.4
7/19/2015	7:00:00 PM	0.4
7/19/2015	7:15:00 PM	0.4
7/19/2015	7:30:00 PM	0.4
7/19/2015	7:45:00 PM	0.4
7/19/2015	8:00:00 PM	0.4
7/19/2015	8:15:00 PM	0.4
7/19/2015	8:30:00 PM	0.4
7/19/2015	8:45:00 PM	0.4
7/19/2015	9:00:00 PM	0.4
7/19/2015	9:15:00 PM	0.4
7/19/2015	9:30:00 PM	0.4
7/19/2015	9:45:00 PM	0.4
7/19/2015	10:00:00 PM	0.4
7/19/2015	10:15:00 PM	0.4
7/19/2015	10:30:00 PM	0.4
7/19/2015	10:45:00 PM	0.4
7/19/2015	11:00:00 PM	0.4
7/19/2015	11:15:00 PM	0.4
7/19/2015	11:30:00 PM	0.4
7/19/2015	11:45:00 PM	0.4
7/20/2015	12:00:00 AM	0.4
7/20/2015	12:15:00 AM	0.4
7/20/2015	12:30:00 AM	0.4
7/20/2015	12:45:00 AM	0.4
7/20/2015	1:00:00 AM	0.4
7/20/2015	1:15:00 AM	0.4
7/20/2015	1:30:00 AM	0.4
7/20/2015	1:45:00 AM	0.4
7/20/2015	2:00:00 AM	0.4
7/20/2015	2:15:00 AM	0.4
7/20/2015	2:30:00 AM	0.4
7/20/2015	2:45:00 AM	0.4
7/20/2015	3:00:00 AM	0.4
7/20/2015	3:15:00 AM	0.4
7/20/2015	3:30:00 AM	0.4
7/20/2015	3:45:00 AM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/20/2015	4:00:00 AM	0.4
7/20/2015	4:15:00 AM	0.4
7/20/2015	4:30:00 AM	0.4
7/20/2015	4:45:00 AM	0.4
7/20/2015	5:00:00 AM	0.41
7/20/2015	5:15:00 AM	0.41
7/20/2015	5:30:00 AM	0.41
7/20/2015	5:45:00 AM	0.41
7/20/2015	6:00:00 AM	0.41
7/20/2015	6:15:00 AM	0.41
7/20/2015	6:30:00 AM	0.41
7/20/2015	6:45:00 AM	0.41
7/20/2015	7:00:00 AM	0.41
7/20/2015	7:15:00 AM	0.41
7/20/2015	7:30:00 AM	0.41
7/20/2015	7:45:00 AM	0.41
7/20/2015	8:00:00 AM	0.41
7/20/2015	8:15:00 AM	0.41
7/20/2015	8:30:00 AM	0.41
7/20/2015	8:45:00 AM	0.42
7/20/2015	9:00:00 AM	0.42
7/20/2015	9:15:00 AM	0.42
7/20/2015	9:30:00 AM	0.42
7/20/2015	9:45:00 AM	0.42
7/20/2015	10:00:00 AM	0.42
7/20/2015	10:15:00 AM	0.42
7/20/2015	10:30:00 AM	0.42
7/20/2015	10:45:00 AM	0.42
7/20/2015	11:00:00 AM	0.42
7/20/2015	11:15:00 AM	0.42
7/20/2015	11:30:00 AM	0.42
7/20/2015	11:45:00 AM	0.42
7/20/2015	12:00:00 PM	0.42
7/20/2015	12:15:00 PM	0.42
7/20/2015	12:30:00 PM	0.42
7/20/2015	12:45:00 PM	0.42
7/20/2015	1:00:00 PM	0.42
7/20/2015	1:15:00 PM	0.42
7/20/2015	1:30:00 PM	0.42
7/20/2015	1:45:00 PM	0.42
7/20/2015	2:00:00 PM	0.42
7/20/2015	2:15:00 PM	0.42
7/20/2015	2:30:00 PM	0.42
7/20/2015	2:45:00 PM	0.42
7/20/2015	3:00:00 PM	0.42
7/20/2015	3:15:00 PM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
7/20/2015	3:30:00 PM	0.42
7/20/2015	3:45:00 PM	0.42
7/20/2015	4:00:00 PM	0.42
7/20/2015	4:15:00 PM	0.42
7/20/2015	4:30:00 PM	0.42
7/20/2015	4:45:00 PM	0.42
7/20/2015	5:00:00 PM	0.42
7/20/2015	5:15:00 PM	0.42
7/20/2015	5:30:00 PM	0.42
7/20/2015	5:45:00 PM	0.42
7/20/2015	6:00:00 PM	0.42
7/20/2015	6:15:00 PM	0.42
7/20/2015	6:30:00 PM	0.42
7/20/2015	6:45:00 PM	0.42
7/20/2015	7:00:00 PM	0.42
7/20/2015	7:15:00 PM	0.42
7/20/2015	7:30:00 PM	0.42
7/20/2015	7:45:00 PM	0.42
7/20/2015	8:00:00 PM	0.42
7/20/2015	8:15:00 PM	0.42
7/20/2015	8:30:00 PM	0.42
7/20/2015	8:45:00 PM	0.42
7/20/2015	9:00:00 PM	0.42
7/20/2015	9:15:00 PM	0.42
7/20/2015	9:30:00 PM	0.42
7/20/2015	9:45:00 PM	0.42
7/20/2015	10:00:00 PM	0.42
7/20/2015	10:15:00 PM	0.42
7/20/2015	10:30:00 PM	0.42
7/20/2015	10:45:00 PM	0.42
7/20/2015	11:00:00 PM	0.42
7/20/2015	11:15:00 PM	0.42
7/20/2015	11:30:00 PM	0.42
7/20/2015	11:45:00 PM	0.42
7/21/2015	12:00:00 AM	0.44
7/21/2015	12:15:00 AM	0.44
7/21/2015	12:30:00 AM	0.44
7/21/2015	12:45:00 AM	0.44
7/21/2015	1:00:00 AM	0.44
7/21/2015	1:15:00 AM	0.44
7/21/2015	1:30:00 AM	0.44
7/21/2015	1:45:00 AM	0.44
7/21/2015	2:00:00 AM	0.44
7/21/2015	2:15:00 AM	0.44
7/21/2015	2:30:00 AM	0.44
7/21/2015	2:45:00 AM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
7/21/2015	3:00:00 AM	0.44
7/21/2015	3:15:00 AM	0.44
7/21/2015	3:30:00 AM	0.44
7/21/2015	3:45:00 AM	0.44
7/21/2015	4:00:00 AM	0.44
7/21/2015	4:15:00 AM	0.44
7/21/2015	4:30:00 AM	0.44
7/21/2015	4:45:00 AM	0.44
7/21/2015	5:00:00 AM	0.44
7/21/2015	5:15:00 AM	0.44
7/21/2015	5:30:00 AM	0.44
7/21/2015	5:45:00 AM	0.44
7/21/2015	6:00:00 AM	0.44
7/21/2015	6:15:00 AM	0.44
7/21/2015	6:30:00 AM	0.44
7/21/2015	6:45:00 AM	0.44
7/21/2015	7:00:00 AM	0.44
7/21/2015	7:15:00 AM	0.44
7/21/2015	7:30:00 AM	0.44
7/21/2015	7:45:00 AM	0.44
7/21/2015	8:00:00 AM	0.44
7/21/2015	8:15:00 AM	0.44
7/21/2015	8:30:00 AM	0.44
7/21/2015	8:45:00 AM	0.44
7/21/2015	9:00:00 AM	0.44
7/21/2015	9:15:00 AM	0.44
7/21/2015	9:30:00 AM	0.44
7/21/2015	9:45:00 AM	0.44
7/21/2015	10:00:00 AM	0.44
7/21/2015	10:15:00 AM	0.44
7/21/2015	10:30:00 AM	0.44
7/21/2015	10:45:00 AM	0.44
7/21/2015	11:00:00 AM	0.44
7/21/2015	11:15:00 AM	0.44
7/21/2015	11:30:00 AM	0.44
7/21/2015	11:45:00 AM	0.44
7/21/2015	12:00:00 PM	0.44
7/21/2015	12:15:00 PM	0.44
7/21/2015	12:30:00 PM	0.44
7/21/2015	12:45:00 PM	0.44
7/21/2015	1:00:00 PM	0.44
7/21/2015	1:15:00 PM	0.44
7/21/2015	1:30:00 PM	0.44
7/21/2015	1:45:00 PM	0.44
7/21/2015	2:00:00 PM	0.44
7/21/2015	2:15:00 PM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
7/21/2015	2:30:00 PM	0.44
7/21/2015	2:45:00 PM	0.44
7/21/2015	3:00:00 PM	0.44
7/21/2015	3:15:00 PM	0.44
7/21/2015	3:30:00 PM	0.44
7/21/2015	3:45:00 PM	0.44
7/21/2015	4:00:00 PM	0.44
7/21/2015	4:15:00 PM	0.44
7/21/2015	4:30:00 PM	0.44
7/21/2015	4:45:00 PM	0.44
7/21/2015	5:00:00 PM	0.44
7/21/2015	5:15:00 PM	0.44
7/21/2015	5:30:00 PM	0.44
7/21/2015	5:45:00 PM	0.44
7/21/2015	6:00:00 PM	0.44
7/21/2015	6:15:00 PM	0.44
7/21/2015	6:30:00 PM	0.44
7/21/2015	6:45:00 PM	0.44
7/21/2015	7:00:00 PM	0.44
7/21/2015	7:15:00 PM	0.44
7/21/2015	7:30:00 PM	0.44
7/21/2015	7:45:00 PM	0.44
7/21/2015	8:00:00 PM	0.44
7/21/2015	8:15:00 PM	0.44
7/21/2015	8:30:00 PM	0.44
7/21/2015	8:45:00 PM	0.44
7/21/2015	9:00:00 PM	0.44
7/21/2015	9:15:00 PM	0.44
7/21/2015	9:30:00 PM	0.44
7/21/2015	9:45:00 PM	0.44
7/21/2015	10:00:00 PM	0.44
7/21/2015	10:15:00 PM	0.44
7/21/2015	10:30:00 PM	0.44
7/21/2015	10:45:00 PM	0.44
7/21/2015	11:00:00 PM	0.44
7/21/2015	11:15:00 PM	0.44
7/21/2015	11:30:00 PM	0.44
7/21/2015	11:45:00 PM	0.44
7/22/2015	12:00:00 AM	0.44
7/22/2015	12:15:00 AM	0.44
7/22/2015	12:30:00 AM	0.44
7/22/2015	12:45:00 AM	0.44
7/22/2015	1:00:00 AM	0.45
7/22/2015	1:15:00 AM	0.45
7/22/2015	1:30:00 AM	0.45
7/22/2015	1:45:00 AM	0.45

Goose Lake Return Gage

DATE	TIME	GAGE
7/22/2015	2:00:00 AM	0.45
7/22/2015	2:15:00 AM	0.45
7/22/2015	2:30:00 AM	0.45
7/22/2015	2:45:00 AM	0.46
7/22/2015	3:00:00 AM	0.46
7/22/2015	3:15:00 AM	0.46
7/22/2015	3:30:00 AM	0.46
7/22/2015	3:45:00 AM	0.46
7/22/2015	4:00:00 AM	0.46
7/22/2015	4:15:00 AM	0.46
7/22/2015	4:30:00 AM	0.46
7/22/2015	4:45:00 AM	0.46
7/22/2015	5:00:00 AM	0.46
7/22/2015	5:15:00 AM	0.46
7/22/2015	5:30:00 AM	0.46
7/22/2015	5:45:00 AM	0.46
7/22/2015	6:00:00 AM	0.46
7/22/2015	6:15:00 AM	0.46
7/22/2015	6:30:00 AM	0.46
7/22/2015	6:45:00 AM	0.46
7/22/2015	7:00:00 AM	0.46
7/22/2015	7:15:00 AM	0.46
7/22/2015	7:30:00 AM	0.46
7/22/2015	7:45:00 AM	0.46
7/22/2015	8:00:00 AM	0.46
7/22/2015	8:15:00 AM	0.46
7/22/2015	8:30:00 AM	0.46
7/22/2015	8:45:00 AM	0.46
7/22/2015	9:00:00 AM	0.46
7/22/2015	9:15:00 AM	0.46
7/22/2015	9:30:00 AM	0.46
7/22/2015	9:45:00 AM	0.46
7/22/2015	10:00:00 AM	0.46
7/22/2015	10:15:00 AM	0.46
7/22/2015	10:30:00 AM	0.46
7/22/2015	10:45:00 AM	0.46
7/22/2015	11:00:00 AM	0.46
7/22/2015	11:15:00 AM	0.46
7/22/2015	11:30:00 AM	0.46
7/22/2015	11:45:00 AM	0.46
7/22/2015	12:00:00 PM	0.46
7/22/2015	12:15:00 PM	0.46
7/22/2015	12:30:00 PM	0.46
7/22/2015	12:45:00 PM	0.46
7/22/2015	1:00:00 PM	0.46
7/22/2015	1:15:00 PM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
7/22/2015	1:30:00 PM	0.46
7/22/2015	1:45:00 PM	0.46
7/22/2015	2:00:00 PM	0.46
7/22/2015	2:15:00 PM	0.46
7/22/2015	2:30:00 PM	0.46
7/22/2015	2:45:00 PM	0.46
7/22/2015	3:00:00 PM	0.46
7/22/2015	3:15:00 PM	0.46
7/22/2015	3:30:00 PM	0.46
7/22/2015	3:45:00 PM	0.46
7/22/2015	4:00:00 PM	0.46
7/22/2015	4:15:00 PM	0.46
7/22/2015	4:30:00 PM	0.46
7/22/2015	4:45:00 PM	0.46
7/22/2015	5:00:00 PM	0.46
7/22/2015	5:15:00 PM	0.46
7/22/2015	5:30:00 PM	0.46
7/22/2015	5:45:00 PM	0.46
7/22/2015	6:00:00 PM	0.46
7/22/2015	6:15:00 PM	0.46
7/22/2015	6:30:00 PM	0.46
7/22/2015	6:45:00 PM	0.46
7/22/2015	7:00:00 PM	0.46
7/22/2015	7:15:00 PM	0.46
7/22/2015	7:30:00 PM	0.46
7/22/2015	7:45:00 PM	0.46
7/22/2015	8:00:00 PM	0.46
7/22/2015	8:15:00 PM	0.46
7/22/2015	8:30:00 PM	0.46
7/22/2015	8:45:00 PM	0.46
7/22/2015	9:00:00 PM	0.46
7/22/2015	9:15:00 PM	0.46
7/22/2015	9:30:00 PM	0.46
7/22/2015	9:45:00 PM	0.46
7/22/2015	10:00:00 PM	0.46
7/22/2015	10:15:00 PM	0.46
7/22/2015	10:30:00 PM	0.46
7/22/2015	10:45:00 PM	0.46
7/22/2015	11:00:00 PM	0.46
7/22/2015	11:15:00 PM	0.46
7/22/2015	11:30:00 PM	0.46
7/22/2015	11:45:00 PM	0.46
7/23/2015	12:00:00 AM	0.46
7/23/2015	12:15:00 AM	0.46
7/23/2015	12:30:00 AM	0.46
7/23/2015	12:45:00 AM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
7/23/2015	1:00:00 AM	0.46
7/23/2015	1:15:00 AM	0.46
7/23/2015	1:30:00 AM	0.46
7/23/2015	1:45:00 AM	0.46
7/23/2015	2:00:00 AM	0.46
7/23/2015	2:15:00 AM	0.46
7/23/2015	2:30:00 AM	0.46
7/23/2015	2:45:00 AM	0.46
7/23/2015	3:00:00 AM	0.46
7/23/2015	3:15:00 AM	0.46
7/23/2015	3:30:00 AM	0.46
7/23/2015	3:45:00 AM	0.46
7/23/2015	4:00:00 AM	0.46
7/23/2015	4:15:00 AM	0.46
7/23/2015	4:30:00 AM	0.46
7/23/2015	4:45:00 AM	0.46
7/23/2015	5:00:00 AM	0.46
7/23/2015	5:15:00 AM	0.46
7/23/2015	5:30:00 AM	0.46
7/23/2015	5:45:00 AM	0.46
7/23/2015	6:00:00 AM	0.46
7/23/2015	6:15:00 AM	0.46
7/23/2015	6:30:00 AM	0.46
7/23/2015	6:45:00 AM	0.46
7/23/2015	7:00:00 AM	0.46
7/23/2015	7:15:00 AM	0.46
7/23/2015	7:30:00 AM	0.46
7/23/2015	7:45:00 AM	0.46
7/23/2015	8:00:00 AM	0.46
7/23/2015	8:15:00 AM	0.46
7/23/2015	8:30:00 AM	0.46
7/23/2015	8:45:00 AM	0.46
7/23/2015	9:00:00 AM	0.46
7/23/2015	9:15:00 AM	0.46
7/23/2015	9:30:00 AM	0.46
7/23/2015	9:45:00 AM	0.46
7/23/2015	10:00:00 AM	0.46
7/23/2015	10:15:00 AM	0.46
7/23/2015	10:30:00 AM	0.46
7/23/2015	10:45:00 AM	0.46
7/23/2015	11:00:00 AM	0.46
7/23/2015	11:15:00 AM	0.46
7/23/2015	11:30:00 AM	0.46
7/23/2015	11:45:00 AM	0.46
7/23/2015	12:00:00 PM	0.46
7/23/2015	12:15:00 PM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
7/23/2015	12:30:00 PM	0.46
7/23/2015	12:45:00 PM	0.46
7/23/2015	1:00:00 PM	0.46
7/23/2015	1:15:00 PM	0.46
7/23/2015	1:30:00 PM	0.46
7/23/2015	1:45:00 PM	0.46
7/23/2015	2:00:00 PM	0.46
7/23/2015	2:15:00 PM	0.46
7/23/2015	2:30:00 PM	0.46
7/23/2015	2:45:00 PM	0.46
7/23/2015	3:00:00 PM	0.46
7/23/2015	3:15:00 PM	0.46
7/23/2015	3:30:00 PM	0.46
7/23/2015	3:45:00 PM	0.46
7/23/2015	4:00:00 PM	0.46
7/23/2015	4:15:00 PM	0.46
7/23/2015	4:30:00 PM	0.46
7/23/2015	4:45:00 PM	0.46
7/23/2015	5:00:00 PM	0.46
7/23/2015	5:15:00 PM	0.46
7/23/2015	5:30:00 PM	0.46
7/23/2015	5:45:00 PM	0.46
7/23/2015	6:00:00 PM	0.46
7/23/2015	6:15:00 PM	0.46
7/23/2015	6:30:00 PM	0.46
7/23/2015	6:45:00 PM	0.46
7/23/2015	7:00:00 PM	0.46
7/23/2015	7:15:00 PM	0.46
7/23/2015	7:30:00 PM	0.46
7/23/2015	7:45:00 PM	0.46
7/23/2015	8:00:00 PM	0.46
7/23/2015	8:15:00 PM	0.46
7/23/2015	8:30:00 PM	0.46
7/23/2015	8:45:00 PM	0.46
7/23/2015	9:00:00 PM	0.46
7/23/2015	9:15:00 PM	0.46
7/23/2015	9:30:00 PM	0.46
7/23/2015	9:45:00 PM	0.46
7/23/2015	10:00:00 PM	0.46
7/23/2015	10:15:00 PM	0.46
7/23/2015	10:30:00 PM	0.46
7/23/2015	10:45:00 PM	0.46
7/23/2015	11:00:00 PM	0.46
7/23/2015	11:15:00 PM	0.46
7/23/2015	11:30:00 PM	0.46
7/23/2015	11:45:00 PM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
7/24/2015	12:00:00 AM	0.46
7/24/2015	12:15:00 AM	0.46
7/24/2015	12:30:00 AM	0.46
7/24/2015	12:45:00 AM	0.46
7/24/2015	1:00:00 AM	0.46
7/24/2015	1:15:00 AM	0.46
7/24/2015	1:30:00 AM	0.46
7/24/2015	1:45:00 AM	0.46
7/24/2015	2:00:00 AM	0.46
7/24/2015	2:15:00 AM	0.46
7/24/2015	2:30:00 AM	0.46
7/24/2015	2:45:00 AM	0.46
7/24/2015	3:00:00 AM	0.46
7/24/2015	3:15:00 AM	0.46
7/24/2015	3:30:00 AM	0.46
7/24/2015	3:45:00 AM	0.46
7/24/2015	4:00:00 AM	0.46
7/24/2015	4:15:00 AM	0.46
7/24/2015	4:30:00 AM	0.46
7/24/2015	4:45:00 AM	0.46
7/24/2015	5:00:00 AM	0.46
7/24/2015	5:15:00 AM	0.46
7/24/2015	5:30:00 AM	0.46
7/24/2015	5:45:00 AM	0.46
7/24/2015	6:00:00 AM	0.46
7/24/2015	6:15:00 AM	0.46
7/24/2015	6:30:00 AM	0.46
7/24/2015	6:45:00 AM	0.46
7/24/2015	7:00:00 AM	0.46
7/24/2015	7:15:00 AM	0.46
7/24/2015	7:30:00 AM	0.46
7/24/2015	7:45:00 AM	0.46
7/24/2015	8:00:00 AM	0.46
7/24/2015	8:15:00 AM	0.46
7/24/2015	8:30:00 AM	0.46
7/24/2015	8:45:00 AM	0.46
7/24/2015	9:00:00 AM	0.46
7/24/2015	9:15:00 AM	0.46
7/24/2015	9:30:00 AM	0.46
7/24/2015	9:45:00 AM	0.46
7/24/2015	10:00:00 AM	0.46
7/24/2015	10:15:00 AM	0.46
7/24/2015	10:30:00 AM	0.46
7/24/2015	10:45:00 AM	0.46
7/24/2015	11:00:00 AM	0.46
7/24/2015	11:15:00 AM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
7/24/2015	11:30:00 AM	0.46
7/24/2015	11:45:00 AM	0.46
7/24/2015	12:00:00 PM	0.46
7/24/2015	12:15:00 PM	0.46
7/24/2015	12:30:00 PM	0.46
7/24/2015	12:45:00 PM	0.46
7/24/2015	1:00:00 PM	0.46
7/24/2015	1:15:00 PM	0.46
7/24/2015	1:30:00 PM	0.46
7/24/2015	1:45:00 PM	0.46
7/24/2015	2:00:00 PM	0.46
7/24/2015	2:15:00 PM	0.46
7/24/2015	2:30:00 PM	0.46
7/24/2015	2:45:00 PM	0.46
7/24/2015	3:00:00 PM	0.46
7/24/2015	3:15:00 PM	0.46
7/24/2015	3:30:00 PM	0.46
7/24/2015	3:45:00 PM	0.46
7/24/2015	4:00:00 PM	0.46
7/24/2015	4:15:00 PM	0.46
7/24/2015	4:30:00 PM	0.46
7/24/2015	4:45:00 PM	0.46
7/24/2015	5:00:00 PM	0.46
7/24/2015	5:15:00 PM	0.46
7/24/2015	5:30:00 PM	0.46
7/24/2015	5:45:00 PM	0.46
7/24/2015	6:00:00 PM	0.46
7/24/2015	6:15:00 PM	0.46
7/24/2015	6:30:00 PM	0.46
7/24/2015	6:45:00 PM	0.46
7/24/2015	7:00:00 PM	0.45
7/24/2015	7:15:00 PM	0.45
7/24/2015	7:30:00 PM	0.45
7/24/2015	7:45:00 PM	0.45
7/24/2015	8:00:00 PM	0.45
7/24/2015	8:15:00 PM	0.45
7/24/2015	8:30:00 PM	0.45
7/24/2015	8:45:00 PM	0.45
7/24/2015	9:00:00 PM	0.45
7/24/2015	9:15:00 PM	0.45
7/24/2015	9:30:00 PM	0.45
7/24/2015	9:45:00 PM	0.45
7/24/2015	10:00:00 PM	0.45
7/24/2015	10:15:00 PM	0.45
7/24/2015	10:30:00 PM	0.45
7/24/2015	10:45:00 PM	0.45

Goose Lake Return Gage

DATE	TIME	GAGE
7/24/2015	11:00:00 PM	0.45
7/24/2015	11:15:00 PM	0.45
7/24/2015	11:30:00 PM	0.45
7/24/2015	11:45:00 PM	0.45
7/25/2015	12:00:00 AM	0.45
7/25/2015	12:15:00 AM	0.45
7/25/2015	12:30:00 AM	0.45
7/25/2015	12:45:00 AM	0.45
7/25/2015	1:00:00 AM	0.45
7/25/2015	1:15:00 AM	0.45
7/25/2015	1:30:00 AM	0.45
7/25/2015	1:45:00 AM	0.45
7/25/2015	2:00:00 AM	0.45
7/25/2015	2:15:00 AM	0.45
7/25/2015	2:30:00 AM	0.45
7/25/2015	2:45:00 AM	0.45
7/25/2015	3:00:00 AM	0.46
7/25/2015	3:15:00 AM	0.46
7/25/2015	3:30:00 AM	0.46
7/25/2015	3:45:00 AM	0.46
7/25/2015	4:00:00 AM	0.46
7/25/2015	4:15:00 AM	0.46
7/25/2015	4:30:00 AM	0.46
7/25/2015	4:45:00 AM	0.46
7/25/2015	5:00:00 AM	0.46
7/25/2015	5:15:00 AM	0.46
7/25/2015	5:30:00 AM	0.46
7/25/2015	5:45:00 AM	0.46
7/25/2015	6:00:00 AM	0.46
7/25/2015	6:15:00 AM	0.46
7/25/2015	6:30:00 AM	0.46
7/25/2015	6:45:00 AM	0.46
7/25/2015	7:00:00 AM	0.46
7/25/2015	7:15:00 AM	0.46
7/25/2015	7:30:00 AM	0.46
7/25/2015	7:45:00 AM	0.46
7/25/2015	8:00:00 AM	0.46
7/25/2015	8:15:00 AM	0.46
7/25/2015	8:30:00 AM	0.46
7/25/2015	8:45:00 AM	0.46
7/25/2015	9:00:00 AM	0.46
7/25/2015	9:15:00 AM	0.46
7/25/2015	9:30:00 AM	0.46
7/25/2015	9:45:00 AM	0.46
7/25/2015	10:00:00 AM	0.46
7/25/2015	10:15:00 AM	0.46

Goose Lake Return Gage

DATE	TIME	GAGE
7/25/2015	10:30:00 AM	0.46
7/25/2015	10:45:00 AM	0.46
7/25/2015	11:00:00 AM	0.46
7/25/2015	11:15:00 AM	0.46
7/25/2015	11:30:00 AM	0.46
7/25/2015	11:45:00 AM	0.46
7/25/2015	12:00:00 PM	0.46
7/25/2015	12:15:00 PM	0.46
7/25/2015	12:30:00 PM	0.46
7/25/2015	12:45:00 PM	0.46
7/25/2015	1:00:00 PM	0.46
7/25/2015	1:15:00 PM	0.46
7/25/2015	1:30:00 PM	0.46
7/25/2015	1:45:00 PM	0.46
7/25/2015	2:00:00 PM	0.46
7/25/2015	2:15:00 PM	0.46
7/25/2015	2:30:00 PM	0.46
7/25/2015	2:45:00 PM	0.46
7/25/2015	3:00:00 PM	0.46
7/25/2015	3:15:00 PM	0.46
7/25/2015	3:30:00 PM	0.46
7/25/2015	3:45:00 PM	0.46
7/25/2015	4:00:00 PM	0.45
7/25/2015	4:15:00 PM	0.45
7/25/2015	4:30:00 PM	0.45
7/25/2015	4:45:00 PM	0.45
7/25/2015	5:00:00 PM	0.45
7/25/2015	5:15:00 PM	0.44
7/25/2015	5:30:00 PM	0.44
7/25/2015	5:45:00 PM	0.44
7/25/2015	6:00:00 PM	0.44
7/25/2015	6:15:00 PM	0.44
7/25/2015	6:30:00 PM	0.44
7/25/2015	6:45:00 PM	0.44
7/25/2015	7:00:00 PM	0.44
7/25/2015	7:15:00 PM	0.44
7/25/2015	7:30:00 PM	0.44
7/25/2015	7:45:00 PM	0.44
7/25/2015	8:00:00 PM	0.44
7/25/2015	8:15:00 PM	0.44
7/25/2015	8:30:00 PM	0.44
7/25/2015	8:45:00 PM	0.44
7/25/2015	9:00:00 PM	0.44
7/25/2015	9:15:00 PM	0.44
7/25/2015	9:30:00 PM	0.44
7/25/2015	9:45:00 PM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
7/25/2015	10:00:00 PM	0.44
7/25/2015	10:15:00 PM	0.44
7/25/2015	10:30:00 PM	0.44
7/25/2015	10:45:00 PM	0.44
7/25/2015	11:00:00 PM	0.44
7/25/2015	11:15:00 PM	0.44
7/25/2015	11:30:00 PM	0.44
7/25/2015	11:45:00 PM	0.44
7/26/2015	12:00:00 AM	0.44
7/26/2015	12:15:00 AM	0.44
7/26/2015	12:30:00 AM	0.44
7/26/2015	12:45:00 AM	0.44
7/26/2015	1:00:00 AM	0.44
7/26/2015	1:15:00 AM	0.44
7/26/2015	1:30:00 AM	0.44
7/26/2015	1:45:00 AM	0.44
7/26/2015	2:00:00 AM	0.44
7/26/2015	2:15:00 AM	0.44
7/26/2015	2:30:00 AM	0.44
7/26/2015	2:45:00 AM	0.44
7/26/2015	3:00:00 AM	0.44
7/26/2015	3:15:00 AM	0.44
7/26/2015	3:30:00 AM	0.44
7/26/2015	3:45:00 AM	0.44
7/26/2015	4:00:00 AM	0.44
7/26/2015	4:15:00 AM	0.44
7/26/2015	4:30:00 AM	0.44
7/26/2015	4:45:00 AM	0.44
7/26/2015	5:00:00 AM	0.44
7/26/2015	5:15:00 AM	0.44
7/26/2015	5:30:00 AM	0.44
7/26/2015	5:45:00 AM	0.44
7/26/2015	6:00:00 AM	0.44
7/26/2015	6:15:00 AM	0.44
7/26/2015	6:30:00 AM	0.44
7/26/2015	6:45:00 AM	0.44
7/26/2015	7:00:00 AM	0.44
7/26/2015	7:15:00 AM	0.44
7/26/2015	7:30:00 AM	0.44
7/26/2015	7:45:00 AM	0.44
7/26/2015	8:00:00 AM	0.44
7/26/2015	8:15:00 AM	0.44
7/26/2015	8:30:00 AM	0.44
7/26/2015	8:45:00 AM	0.44
7/26/2015	9:00:00 AM	0.44
7/26/2015	9:15:00 AM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
7/26/2015	9:30:00 AM	0.44
7/26/2015	9:45:00 AM	0.44
7/26/2015	10:00:00 AM	0.44
7/26/2015	10:15:00 AM	0.44
7/26/2015	10:30:00 AM	0.44
7/26/2015	10:45:00 AM	0.44
7/26/2015	11:00:00 AM	0.44
7/26/2015	11:15:00 AM	0.44
7/26/2015	11:30:00 AM	0.44
7/26/2015	11:45:00 AM	0.44
7/26/2015	12:00:00 PM	0.44
7/26/2015	12:15:00 PM	0.44
7/26/2015	12:30:00 PM	0.44
7/26/2015	12:45:00 PM	0.44
7/26/2015	1:00:00 PM	0.44
7/26/2015	1:15:00 PM	0.44
7/26/2015	1:30:00 PM	0.44
7/26/2015	1:45:00 PM	0.44
7/26/2015	2:00:00 PM	0.44
7/26/2015	2:15:00 PM	0.44
7/26/2015	2:30:00 PM	0.44
7/26/2015	2:45:00 PM	0.44
7/26/2015	3:00:00 PM	0.44
7/26/2015	3:15:00 PM	0.44
7/26/2015	3:30:00 PM	0.44
7/26/2015	3:45:00 PM	0.44
7/26/2015	4:00:00 PM	0.44
7/26/2015	4:15:00 PM	0.44
7/26/2015	4:30:00 PM	0.44
7/26/2015	4:45:00 PM	0.44
7/26/2015	5:00:00 PM	0.44
7/26/2015	5:15:00 PM	0.44
7/26/2015	5:30:00 PM	0.44
7/26/2015	5:45:00 PM	0.44
7/26/2015	6:00:00 PM	0.44
7/26/2015	6:15:00 PM	0.44
7/26/2015	6:30:00 PM	0.44
7/26/2015	6:45:00 PM	0.43
7/26/2015	7:00:00 PM	0.43
7/26/2015	7:15:00 PM	0.43
7/26/2015	7:30:00 PM	0.43
7/26/2015	7:45:00 PM	0.43
7/26/2015	8:00:00 PM	0.43
7/26/2015	8:15:00 PM	0.43
7/26/2015	8:30:00 PM	0.43
7/26/2015	8:45:00 PM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
7/26/2015	9:00:00 PM	0.43
7/26/2015	9:15:00 PM	0.43
7/26/2015	9:30:00 PM	0.43
7/26/2015	9:45:00 PM	0.43
7/26/2015	10:00:00 PM	0.43
7/26/2015	10:15:00 PM	0.43
7/26/2015	10:30:00 PM	0.43
7/26/2015	10:45:00 PM	0.43
7/26/2015	11:00:00 PM	0.43
7/26/2015	11:15:00 PM	0.43
7/26/2015	11:30:00 PM	0.43
7/26/2015	11:45:00 PM	0.43
7/27/2015	12:00:00 AM	0.43
7/27/2015	12:15:00 AM	0.43
7/27/2015	12:30:00 AM	0.43
7/27/2015	12:45:00 AM	0.43
7/27/2015	1:00:00 AM	0.43
7/27/2015	1:15:00 AM	0.43
7/27/2015	1:30:00 AM	0.43
7/27/2015	1:45:00 AM	0.43
7/27/2015	2:00:00 AM	0.43
7/27/2015	2:15:00 AM	0.43
7/27/2015	2:30:00 AM	0.43
7/27/2015	2:45:00 AM	0.43
7/27/2015	3:00:00 AM	0.43
7/27/2015	3:15:00 AM	0.43
7/27/2015	3:30:00 AM	0.43
7/27/2015	3:45:00 AM	0.43
7/27/2015	4:00:00 AM	0.43
7/27/2015	4:15:00 AM	0.43
7/27/2015	4:30:00 AM	0.43
7/27/2015	4:45:00 AM	0.43
7/27/2015	5:00:00 AM	0.43
7/27/2015	5:15:00 AM	0.43
7/27/2015	5:30:00 AM	0.43
7/27/2015	5:45:00 AM	0.43
7/27/2015	6:00:00 AM	0.43
7/27/2015	6:15:00 AM	0.43
7/27/2015	6:30:00 AM	0.43
7/27/2015	6:45:00 AM	0.43
7/27/2015	7:00:00 AM	0.43
7/27/2015	7:15:00 AM	0.43
7/27/2015	7:30:00 AM	0.44
7/27/2015	7:45:00 AM	0.44
7/27/2015	8:00:00 AM	0.44
7/27/2015	8:15:00 AM	0.44

Goose Lake Return Gage

DATE	TIME	GAGE
7/27/2015	8:30:00 AM	0.44
7/27/2015	8:45:00 AM	0.44
7/27/2015	9:00:00 AM	0.44
7/27/2015	9:15:00 AM	0.44
7/27/2015	9:30:00 AM	0.44
7/27/2015	9:45:00 AM	0.44
7/27/2015	10:00:00 AM	0.44
7/27/2015	10:15:00 AM	0.44
7/27/2015	10:30:00 AM	0.44
7/27/2015	10:45:00 AM	0.44
7/27/2015	11:00:00 AM	0.44
7/27/2015	11:15:00 AM	0.44
7/27/2015	11:30:00 AM	0.44
7/27/2015	11:45:00 AM	0.44
7/27/2015	12:00:00 PM	0.43
7/27/2015	12:15:00 PM	0.43
7/27/2015	12:30:00 PM	0.43
7/27/2015	12:45:00 PM	0.43
7/27/2015	1:00:00 PM	0.43
7/27/2015	1:15:00 PM	0.43
7/27/2015	1:30:00 PM	0.43
7/27/2015	1:45:00 PM	0.43
7/27/2015	2:00:00 PM	0.43
7/27/2015	2:15:00 PM	0.43
7/27/2015	2:30:00 PM	0.43
7/27/2015	2:45:00 PM	0.42
7/27/2015	3:00:00 PM	0.42
7/27/2015	3:15:00 PM	0.42
7/27/2015	3:30:00 PM	0.42
7/27/2015	3:45:00 PM	0.42
7/27/2015	4:00:00 PM	0.42
7/27/2015	4:15:00 PM	0.42
7/27/2015	4:30:00 PM	0.42
7/27/2015	4:45:00 PM	0.42
7/27/2015	5:00:00 PM	0.42
7/27/2015	5:15:00 PM	0.42
7/27/2015	5:30:00 PM	0.42
7/27/2015	5:45:00 PM	0.42
7/27/2015	6:00:00 PM	0.42
7/27/2015	6:15:00 PM	0.42
7/27/2015	6:30:00 PM	0.42
7/27/2015	6:45:00 PM	0.42
7/27/2015	7:00:00 PM	0.42
7/27/2015	7:15:00 PM	0.42
7/27/2015	7:30:00 PM	0.42
7/27/2015	7:45:00 PM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
7/27/2015	8:00:00 PM	0.42
7/27/2015	8:15:00 PM	0.42
7/27/2015	8:30:00 PM	0.42
7/27/2015	8:45:00 PM	0.42
7/27/2015	9:00:00 PM	0.42
7/27/2015	9:15:00 PM	0.42
7/27/2015	9:30:00 PM	0.42
7/27/2015	9:45:00 PM	0.42
7/27/2015	10:00:00 PM	0.42
7/27/2015	10:15:00 PM	0.42
7/27/2015	10:30:00 PM	0.42
7/27/2015	10:45:00 PM	0.42
7/27/2015	11:00:00 PM	0.42
7/27/2015	11:15:00 PM	0.42
7/27/2015	11:30:00 PM	0.42
7/27/2015	11:45:00 PM	0.42
7/28/2015	12:00:00 AM	0.42
7/28/2015	12:15:00 AM	0.42
7/28/2015	12:30:00 AM	0.42
7/28/2015	12:45:00 AM	0.42
7/28/2015	1:00:00 AM	0.42
7/28/2015	1:15:00 AM	0.42
7/28/2015	1:30:00 AM	0.42
7/28/2015	1:45:00 AM	0.42
7/28/2015	2:00:00 AM	0.42
7/28/2015	2:15:00 AM	0.42
7/28/2015	2:30:00 AM	0.42
7/28/2015	2:45:00 AM	0.42
7/28/2015	3:00:00 AM	0.42
7/28/2015	3:15:00 AM	0.42
7/28/2015	3:30:00 AM	0.42
7/28/2015	3:45:00 AM	0.42
7/28/2015	4:00:00 AM	0.42
7/28/2015	4:15:00 AM	0.42
7/28/2015	4:30:00 AM	0.42
7/28/2015	4:45:00 AM	0.42
7/28/2015	5:00:00 AM	0.42
7/28/2015	5:15:00 AM	0.42
7/28/2015	5:30:00 AM	0.42
7/28/2015	5:45:00 AM	0.42
7/28/2015	6:00:00 AM	0.42
7/28/2015	6:15:00 AM	0.42
7/28/2015	6:30:00 AM	0.42
7/28/2015	6:45:00 AM	0.42
7/28/2015	7:00:00 AM	0.42
7/28/2015	7:15:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
7/28/2015	7:30:00 AM	0.42
7/28/2015	7:45:00 AM	0.42
7/28/2015	8:00:00 AM	0.42
7/28/2015	8:15:00 AM	0.42
7/28/2015	8:30:00 AM	0.42
7/28/2015	8:45:00 AM	0.42
7/28/2015	9:00:00 AM	0.42
7/28/2015	9:15:00 AM	0.42
7/28/2015	9:30:00 AM	0.42
7/28/2015	9:45:00 AM	0.42
7/28/2015	10:00:00 AM	0.42
7/28/2015	10:15:00 AM	0.42
7/28/2015	10:30:00 AM	0.42
7/28/2015	10:45:00 AM	0.42
7/28/2015	11:00:00 AM	0.42
7/28/2015	11:15:00 AM	0.42
7/28/2015	11:30:00 AM	0.42
7/28/2015	11:45:00 AM	0.42
7/28/2015	12:00:00 PM	0.42
7/28/2015	12:15:00 PM	0.42
7/28/2015	12:30:00 PM	0.42
7/28/2015	12:45:00 PM	0.41
7/28/2015	1:00:00 PM	0.41
7/28/2015	1:15:00 PM	0.41
7/28/2015	1:30:00 PM	0.41
7/28/2015	1:45:00 PM	0.41
7/28/2015	2:00:00 PM	0.41
7/28/2015	2:15:00 PM	0.4
7/28/2015	2:30:00 PM	0.4
7/28/2015	2:45:00 PM	0.4
7/28/2015	3:00:00 PM	0.4
7/28/2015	3:15:00 PM	0.4
7/28/2015	3:30:00 PM	0.4
7/28/2015	3:45:00 PM	0.4
7/28/2015	4:00:00 PM	0.4
7/28/2015	4:15:00 PM	0.4
7/28/2015	4:30:00 PM	0.4
7/28/2015	4:45:00 PM	0.4
7/28/2015	5:00:00 PM	0.4
7/28/2015	5:15:00 PM	0.4
7/28/2015	5:30:00 PM	0.4
7/28/2015	5:45:00 PM	0.4
7/28/2015	6:00:00 PM	0.4
7/28/2015	6:15:00 PM	0.4
7/28/2015	6:30:00 PM	0.4
7/28/2015	6:45:00 PM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/28/2015	7:00:00 PM	0.4
7/28/2015	7:15:00 PM	0.4
7/28/2015	7:30:00 PM	0.4
7/28/2015	7:45:00 PM	0.39
7/28/2015	8:00:00 PM	0.39
7/28/2015	8:15:00 PM	0.39
7/28/2015	8:30:00 PM	0.39
7/28/2015	8:45:00 PM	0.39
7/28/2015	9:00:00 PM	0.39
7/28/2015	9:15:00 PM	0.39
7/28/2015	9:30:00 PM	0.39
7/28/2015	9:45:00 PM	0.39
7/28/2015	10:00:00 PM	0.39
7/28/2015	10:15:00 PM	0.39
7/28/2015	10:30:00 PM	0.39
7/28/2015	10:45:00 PM	0.39
7/28/2015	11:00:00 PM	0.39
7/28/2015	11:15:00 PM	0.39
7/28/2015	11:30:00 PM	0.39
7/28/2015	11:45:00 PM	0.39
7/29/2015	12:00:00 AM	0.4
7/29/2015	12:15:00 AM	0.4
7/29/2015	12:30:00 AM	0.4
7/29/2015	12:45:00 AM	0.4
7/29/2015	1:00:00 AM	0.4
7/29/2015	1:15:00 AM	0.4
7/29/2015	1:30:00 AM	0.4
7/29/2015	1:45:00 AM	0.4
7/29/2015	2:00:00 AM	0.4
7/29/2015	2:15:00 AM	0.4
7/29/2015	2:30:00 AM	0.4
7/29/2015	2:45:00 AM	0.4
7/29/2015	3:00:00 AM	0.4
7/29/2015	3:15:00 AM	0.4
7/29/2015	3:30:00 AM	0.4
7/29/2015	3:45:00 AM	0.4
7/29/2015	4:00:00 AM	0.4
7/29/2015	4:15:00 AM	0.4
7/29/2015	4:30:00 AM	0.4
7/29/2015	4:45:00 AM	0.4
7/29/2015	5:00:00 AM	0.4
7/29/2015	5:15:00 AM	0.4
7/29/2015	5:30:00 AM	0.4
7/29/2015	5:45:00 AM	0.4
7/29/2015	6:00:00 AM	0.4
7/29/2015	6:15:00 AM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/29/2015	6:30:00 AM	0.4
7/29/2015	6:45:00 AM	0.4
7/29/2015	7:00:00 AM	0.4
7/29/2015	7:15:00 AM	0.4
7/29/2015	7:30:00 AM	0.4
7/29/2015	7:45:00 AM	0.4
7/29/2015	8:00:00 AM	0.4
7/29/2015	8:15:00 AM	0.4
7/29/2015	8:30:00 AM	0.4
7/29/2015	8:45:00 AM	0.4
7/29/2015	9:00:00 AM	0.4
7/29/2015	9:15:00 AM	0.4
7/29/2015	9:30:00 AM	0.4
7/29/2015	9:45:00 AM	0.4
7/29/2015	10:00:00 AM	0.4
7/29/2015	10:15:00 AM	0.4
7/29/2015	10:30:00 AM	0.4
7/29/2015	10:45:00 AM	0.4
7/29/2015	11:00:00 AM	0.4
7/29/2015	11:15:00 AM	0.4
7/29/2015	11:30:00 AM	0.4
7/29/2015	11:45:00 AM	0.4
7/29/2015	12:00:00 PM	0.4
7/29/2015	12:15:00 PM	0.4
7/29/2015	12:30:00 PM	0.4
7/29/2015	12:45:00 PM	0.4
7/29/2015	1:00:00 PM	0.4
7/29/2015	1:15:00 PM	0.4
7/29/2015	1:30:00 PM	0.4
7/29/2015	1:45:00 PM	0.4
7/29/2015	2:00:00 PM	0.4
7/29/2015	2:15:00 PM	0.4
7/29/2015	2:30:00 PM	0.4
7/29/2015	2:45:00 PM	0.4
7/29/2015	3:00:00 PM	0.4
7/29/2015	3:15:00 PM	0.4
7/29/2015	3:30:00 PM	0.4
7/29/2015	3:45:00 PM	0.4
7/29/2015	4:00:00 PM	0.4
7/29/2015	4:15:00 PM	0.4
7/29/2015	4:30:00 PM	0.4
7/29/2015	4:45:00 PM	0.4
7/29/2015	5:00:00 PM	0.4
7/29/2015	5:15:00 PM	0.4
7/29/2015	5:30:00 PM	0.4
7/29/2015	5:45:00 PM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/29/2015	6:00:00 PM	0.4
7/29/2015	6:15:00 PM	0.4
7/29/2015	6:30:00 PM	0.4
7/29/2015	6:45:00 PM	0.4
7/29/2015	7:00:00 PM	0.4
7/29/2015	7:15:00 PM	0.4
7/29/2015	7:30:00 PM	0.4
7/29/2015	7:45:00 PM	0.4
7/29/2015	8:00:00 PM	0.4
7/29/2015	8:15:00 PM	0.4
7/29/2015	8:30:00 PM	0.4
7/29/2015	8:45:00 PM	0.4
7/29/2015	9:00:00 PM	0.4
7/29/2015	9:15:00 PM	0.4
7/29/2015	9:30:00 PM	0.4
7/29/2015	9:45:00 PM	0.4
7/29/2015	10:00:00 PM	0.4
7/29/2015	10:15:00 PM	0.4
7/29/2015	10:30:00 PM	0.4
7/29/2015	10:45:00 PM	0.4
7/29/2015	11:00:00 PM	0.4
7/29/2015	11:15:00 PM	0.4
7/29/2015	11:30:00 PM	0.4
7/29/2015	11:45:00 PM	0.4
7/30/2015	12:00:00 AM	0.4
7/30/2015	12:15:00 AM	0.4
7/30/2015	12:30:00 AM	0.4
7/30/2015	12:45:00 AM	0.4
7/30/2015	1:00:00 AM	0.4
7/30/2015	1:15:00 AM	0.4
7/30/2015	1:30:00 AM	0.4
7/30/2015	1:45:00 AM	0.4
7/30/2015	2:00:00 AM	0.4
7/30/2015	2:15:00 AM	0.4
7/30/2015	2:30:00 AM	0.4
7/30/2015	2:45:00 AM	0.4
7/30/2015	3:00:00 AM	0.4
7/30/2015	3:15:00 AM	0.4
7/30/2015	3:30:00 AM	0.4
7/30/2015	3:45:00 AM	0.4
7/30/2015	4:00:00 AM	0.4
7/30/2015	4:15:00 AM	0.4
7/30/2015	4:30:00 AM	0.4
7/30/2015	4:45:00 AM	0.4
7/30/2015	5:00:00 AM	0.4
7/30/2015	5:15:00 AM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/30/2015	5:30:00 AM	0.4
7/30/2015	5:45:00 AM	0.4
7/30/2015	6:00:00 AM	0.4
7/30/2015	6:15:00 AM	0.4
7/30/2015	6:30:00 AM	0.4
7/30/2015	6:45:00 AM	0.4
7/30/2015	7:00:00 AM	0.4
7/30/2015	7:15:00 AM	0.4
7/30/2015	7:30:00 AM	0.4
7/30/2015	7:45:00 AM	0.4
7/30/2015	8:00:00 AM	0.4
7/30/2015	8:15:00 AM	0.4
7/30/2015	8:30:00 AM	0.4
7/30/2015	8:45:00 AM	0.4
7/30/2015	9:00:00 AM	0.4
7/30/2015	9:15:00 AM	0.4
7/30/2015	9:30:00 AM	0.4
7/30/2015	9:45:00 AM	0.4
7/30/2015	10:00:00 AM	0.4
7/30/2015	10:15:00 AM	0.4
7/30/2015	10:30:00 AM	0.4
7/30/2015	10:45:00 AM	0.4
7/30/2015	11:00:00 AM	0.4
7/30/2015	11:15:00 AM	0.4
7/30/2015	11:30:00 AM	0.4
7/30/2015	11:45:00 AM	0.4
7/30/2015	12:00:00 PM	0.4
7/30/2015	12:15:00 PM	0.4
7/30/2015	12:30:00 PM	0.4
7/30/2015	12:45:00 PM	0.4
7/30/2015	1:00:00 PM	0.4
7/30/2015	1:15:00 PM	0.4
7/30/2015	1:30:00 PM	0.4
7/30/2015	1:45:00 PM	0.4
7/30/2015	2:00:00 PM	0.4
7/30/2015	2:15:00 PM	0.4
7/30/2015	2:30:00 PM	0.4
7/30/2015	2:45:00 PM	0.4
7/30/2015	3:00:00 PM	0.4
7/30/2015	3:15:00 PM	0.4
7/30/2015	3:30:00 PM	0.4
7/30/2015	3:45:00 PM	0.4
7/30/2015	4:00:00 PM	0.4
7/30/2015	4:15:00 PM	0.4
7/30/2015	4:30:00 PM	0.4
7/30/2015	4:45:00 PM	0.4

Goose Lake Return Gage

DATE	TIME	GAGE
7/30/2015	5:00:00 PM	0.4
7/30/2015	5:15:00 PM	0.4
7/30/2015	5:30:00 PM	0.4
7/30/2015	5:45:00 PM	0.4
7/30/2015	6:00:00 PM	0.4
7/30/2015	6:15:00 PM	0.4
7/30/2015	6:30:00 PM	0.4
7/30/2015	6:45:00 PM	0.4
7/30/2015	7:00:00 PM	0.4
7/30/2015	7:15:00 PM	0.4
7/30/2015	7:30:00 PM	0.4
7/30/2015	7:45:00 PM	0.4
7/30/2015	8:00:00 PM	0.4
7/30/2015	8:15:00 PM	0.4
7/30/2015	8:30:00 PM	0.4
7/30/2015	8:45:00 PM	0.4
7/30/2015	9:00:00 PM	0.4
7/30/2015	9:15:00 PM	0.4
7/30/2015	9:30:00 PM	0.4
7/30/2015	9:45:00 PM	0.4
7/30/2015	10:00:00 PM	0.41
7/30/2015	10:15:00 PM	0.41
7/30/2015	10:30:00 PM	0.41
7/30/2015	10:45:00 PM	0.41
7/30/2015	11:00:00 PM	0.41
7/30/2015	11:15:00 PM	0.41
7/30/2015	11:30:00 PM	0.41
7/30/2015	11:45:00 PM	0.41
7/31/2015	12:00:00 AM	0.41
7/31/2015	12:15:00 AM	0.41
7/31/2015	12:30:00 AM	0.41
7/31/2015	12:45:00 AM	0.41
7/31/2015	1:00:00 AM	0.41
7/31/2015	1:15:00 AM	0.42
7/31/2015	1:30:00 AM	0.42
7/31/2015	1:45:00 AM	0.42
7/31/2015	2:00:00 AM	0.42
7/31/2015	2:15:00 AM	0.42
7/31/2015	2:30:00 AM	0.42
7/31/2015	2:45:00 AM	0.42
7/31/2015	3:00:00 AM	0.42
7/31/2015	3:15:00 AM	0.42
7/31/2015	3:30:00 AM	0.42
7/31/2015	3:45:00 AM	0.42
7/31/2015	4:00:00 AM	0.42
7/31/2015	4:15:00 AM	0.42

Goose Lake Return Gage

DATE	TIME	GAGE
7/31/2015	4:30:00 AM	0.42
7/31/2015	4:45:00 AM	0.42
7/31/2015	5:00:00 AM	0.42
7/31/2015	5:15:00 AM	0.42
7/31/2015	5:30:00 AM	0.42
7/31/2015	5:45:00 AM	0.42
7/31/2015	6:00:00 AM	0.42
7/31/2015	6:15:00 AM	0.42
7/31/2015	6:30:00 AM	0.42
7/31/2015	6:45:00 AM	0.42
7/31/2015	7:00:00 AM	0.42
7/31/2015	7:15:00 AM	0.42
7/31/2015	7:30:00 AM	0.42
7/31/2015	7:45:00 AM	0.42
7/31/2015	8:00:00 AM	0.42
7/31/2015	8:15:00 AM	0.42
7/31/2015	8:30:00 AM	0.42
7/31/2015	8:45:00 AM	0.42
7/31/2015	9:00:00 AM	0.42
7/31/2015	9:15:00 AM	0.42
7/31/2015	9:30:00 AM	0.42
7/31/2015	9:45:00 AM	0.42
7/31/2015	10:00:00 AM	0.42
7/31/2015	10:15:00 AM	0.42
7/31/2015	10:30:00 AM	0.42
7/31/2015	10:45:00 AM	0.42
7/31/2015	11:00:00 AM	0.42
7/31/2015	11:15:00 AM	0.42
7/31/2015	11:30:00 AM	0.42
7/31/2015	11:45:00 AM	0.42
7/31/2015	12:00:00 PM	0.42
7/31/2015	12:15:00 PM	0.43
7/31/2015	12:30:00 PM	0.43
7/31/2015	12:45:00 PM	0.43
7/31/2015	1:00:00 PM	0.43
7/31/2015	1:15:00 PM	0.43
7/31/2015	1:30:00 PM	0.43
7/31/2015	1:45:00 PM	0.43
7/31/2015	2:00:00 PM	0.43
7/31/2015	2:15:00 PM	0.43
7/31/2015	2:30:00 PM	0.43
7/31/2015	2:45:00 PM	0.43
7/31/2015	3:00:00 PM	0.43
7/31/2015	3:15:00 PM	0.43
7/31/2015	3:30:00 PM	0.43
7/31/2015	3:45:00 PM	0.43

Goose Lake Return Gage

DATE	TIME	GAGE
7/31/2015	4:00:00 PM	0.43
7/31/2015	4:15:00 PM	0.43
7/31/2015	4:30:00 PM	0.43
7/31/2015	4:45:00 PM	0.43
7/31/2015	5:00:00 PM	0.43
7/31/2015	5:15:00 PM	0.43
7/31/2015	5:30:00 PM	0.43
7/31/2015	5:45:00 PM	0.43
7/31/2015	6:00:00 PM	0.43
7/31/2015	6:15:00 PM	0.43
7/31/2015	6:30:00 PM	0.43
7/31/2015	6:45:00 PM	0.43
7/31/2015	7:00:00 PM	0.43
7/31/2015	7:15:00 PM	0.43
7/31/2015	7:30:00 PM	0.43
7/31/2015	7:45:00 PM	0.43
7/31/2015	8:00:00 PM	0.43
7/31/2015	8:15:00 PM	0.43
7/31/2015	8:30:00 PM	0.43
7/31/2015	8:45:00 PM	0.43
7/31/2015	9:00:00 PM	0.43
7/31/2015	9:15:00 PM	0.43
7/31/2015	9:30:00 PM	0.43
7/31/2015	9:45:00 PM	0.43
7/31/2015	10:00:00 PM	0.43
7/31/2015	10:15:00 PM	0.43
7/31/2015	10:30:00 PM	0.43
7/31/2015	10:45:00 PM	0.43
7/31/2015	11:00:00 PM	0.43
7/31/2015	11:15:00 PM	0.43
7/31/2015	11:30:00 PM	0.43
7/31/2015	11:45:00 PM	0.44

Billy Lake Return

Station 0213

Date	Flow (cfs)
7/1/2015	1.014
7/2/2015	1.154
7/3/2015	1.29
7/4/2015	1.302
7/5/2015	1.302
7/6/2015	1.324
7/7/2015	1.368
7/8/2015	1.383
7/9/2015	1.368
7/10/2015	1.341
7/11/2015	1.302
7/12/2015	1.302
7/13/2015	1.286
7/14/2015	1.198
7/15/2015	1.057
7/16/2015	0.944
7/17/2015	0.834
7/18/2015	0.726
7/19/2015	0.643
7/20/2015	0.689
7/21/2015	0.871
7/22/2015	0.933
7/23/2015	0.977
7/24/2015	1.05
7/25/2015	1.063
7/26/2015	1.002
7/27/2015	0.884
7/28/2015	0.771
7/29/2015	0.804
7/30/2015	0.979
7/31/2015	0.992

Billy Lake Return Gage

DATE	TIME	GAGE
7/1/2015	12:00:00 AM	0.26
7/1/2015	12:15:00 AM	0.26
7/1/2015	12:30:00 AM	0.26
7/1/2015	12:45:00 AM	0.26
7/1/2015	1:00:00 AM	0.26
7/1/2015	1:15:00 AM	0.26
7/1/2015	1:30:00 AM	0.26
7/1/2015	1:45:00 AM	0.26
7/1/2015	2:00:00 AM	0.26
7/1/2015	2:15:00 AM	0.26
7/1/2015	2:30:00 AM	0.26
7/1/2015	2:45:00 AM	0.26
7/1/2015	3:00:00 AM	0.26
7/1/2015	3:15:00 AM	0.26
7/1/2015	3:30:00 AM	0.26
7/1/2015	3:45:00 AM	0.26
7/1/2015	4:00:00 AM	0.26
7/1/2015	4:15:00 AM	0.26
7/1/2015	4:30:00 AM	0.26
7/1/2015	4:45:00 AM	0.26
7/1/2015	5:00:00 AM	0.26
7/1/2015	5:15:00 AM	0.26
7/1/2015	5:30:00 AM	0.26
7/1/2015	5:45:00 AM	0.26
7/1/2015	6:00:00 AM	0.26
7/1/2015	6:15:00 AM	0.26
7/1/2015	6:30:00 AM	0.26
7/1/2015	6:45:00 AM	0.26
7/1/2015	7:00:00 AM	0.26
7/1/2015	7:15:00 AM	0.26
7/1/2015	7:30:00 AM	0.26
7/1/2015	7:45:00 AM	0.26
7/1/2015	8:00:00 AM	0.26
7/1/2015	8:15:00 AM	0.26
7/1/2015	8:30:00 AM	0.26
7/1/2015	8:45:00 AM	0.26
7/1/2015	9:00:00 AM	0.26
7/1/2015	9:15:00 AM	0.26
7/1/2015	9:30:00 AM	0.26
7/1/2015	9:45:00 AM	0.26
7/1/2015	10:00:00 AM	0.26
7/1/2015	10:15:00 AM	0.26
7/1/2015	10:30:00 AM	0.26
7/1/2015	10:45:00 AM	0.26
7/1/2015	11:00:00 AM	0.26
7/1/2015	11:15:00 AM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
7/1/2015	11:30:00 AM	0.26
7/1/2015	11:45:00 AM	0.26
7/1/2015	12:00:00 PM	0.26
7/1/2015	12:15:00 PM	0.26
7/1/2015	12:30:00 PM	0.26
7/1/2015	12:45:00 PM	0.26
7/1/2015	1:00:00 PM	0.26
7/1/2015	1:15:00 PM	0.26
7/1/2015	1:30:00 PM	0.26
7/1/2015	1:45:00 PM	0.26
7/1/2015	2:00:00 PM	0.26
7/1/2015	2:15:00 PM	0.26
7/1/2015	2:30:00 PM	0.26
7/1/2015	2:45:00 PM	0.26
7/1/2015	3:00:00 PM	0.27
7/1/2015	3:15:00 PM	0.27
7/1/2015	3:30:00 PM	0.27
7/1/2015	3:45:00 PM	0.27
7/1/2015	4:00:00 PM	0.27
7/1/2015	4:15:00 PM	0.27
7/1/2015	4:30:00 PM	0.27
7/1/2015	4:45:00 PM	0.27
7/1/2015	5:00:00 PM	0.27
7/1/2015	5:15:00 PM	0.27
7/1/2015	5:30:00 PM	0.27
7/1/2015	5:45:00 PM	0.27
7/1/2015	6:00:00 PM	0.27
7/1/2015	6:15:00 PM	0.27
7/1/2015	6:30:00 PM	0.27
7/1/2015	6:45:00 PM	0.27
7/1/2015	7:00:00 PM	0.27
7/1/2015	7:15:00 PM	0.27
7/1/2015	7:30:00 PM	0.27
7/1/2015	7:45:00 PM	0.27
7/1/2015	8:00:00 PM	0.27
7/1/2015	8:15:00 PM	0.27
7/1/2015	8:30:00 PM	0.27
7/1/2015	8:45:00 PM	0.27
7/1/2015	9:00:00 PM	0.27
7/1/2015	9:15:00 PM	0.27
7/1/2015	9:30:00 PM	0.27
7/1/2015	9:45:00 PM	0.27
7/1/2015	10:00:00 PM	0.27
7/1/2015	10:15:00 PM	0.27
7/1/2015	10:30:00 PM	0.27
7/1/2015	10:45:00 PM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/1/2015	11:00:00 PM	0.27
7/1/2015	11:15:00 PM	0.27
7/1/2015	11:30:00 PM	0.27
7/1/2015	11:45:00 PM	0.27
7/2/2015	12:00:00 AM	0.27
7/2/2015	12:15:00 AM	0.27
7/2/2015	12:30:00 AM	0.27
7/2/2015	12:45:00 AM	0.27
7/2/2015	1:00:00 AM	0.27
7/2/2015	1:15:00 AM	0.27
7/2/2015	1:30:00 AM	0.27
7/2/2015	1:45:00 AM	0.27
7/2/2015	2:00:00 AM	0.28
7/2/2015	2:15:00 AM	0.28
7/2/2015	2:30:00 AM	0.28
7/2/2015	2:45:00 AM	0.28
7/2/2015	3:00:00 AM	0.28
7/2/2015	3:15:00 AM	0.28
7/2/2015	3:30:00 AM	0.28
7/2/2015	3:45:00 AM	0.28
7/2/2015	4:00:00 AM	0.28
7/2/2015	4:15:00 AM	0.28
7/2/2015	4:30:00 AM	0.28
7/2/2015	4:45:00 AM	0.28
7/2/2015	5:00:00 AM	0.28
7/2/2015	5:15:00 AM	0.28
7/2/2015	5:30:00 AM	0.28
7/2/2015	5:45:00 AM	0.28
7/2/2015	6:00:00 AM	0.28
7/2/2015	6:15:00 AM	0.28
7/2/2015	6:30:00 AM	0.28
7/2/2015	6:45:00 AM	0.28
7/2/2015	7:00:00 AM	0.28
7/2/2015	7:15:00 AM	0.28
7/2/2015	7:30:00 AM	0.28
7/2/2015	7:45:00 AM	0.28
7/2/2015	8:00:00 AM	0.28
7/2/2015	8:15:00 AM	0.28
7/2/2015	8:30:00 AM	0.28
7/2/2015	8:45:00 AM	0.28
7/2/2015	9:00:00 AM	0.28
7/2/2015	9:15:00 AM	0.28
7/2/2015	9:30:00 AM	0.28
7/2/2015	9:45:00 AM	0.28
7/2/2015	10:00:00 AM	0.29
7/2/2015	10:15:00 AM	0.29

Billy Lake Return Gage

DATE	TIME	GAGE
7/2/2015	10:30:00 AM	0.29
7/2/2015	10:45:00 AM	0.29
7/2/2015	11:00:00 AM	0.29
7/2/2015	11:15:00 AM	0.29
7/2/2015	11:30:00 AM	0.29
7/2/2015	11:45:00 AM	0.29
7/2/2015	12:00:00 PM	0.29
7/2/2015	12:15:00 PM	0.29
7/2/2015	12:30:00 PM	0.29
7/2/2015	12:45:00 PM	0.29
7/2/2015	1:00:00 PM	0.29
7/2/2015	1:15:00 PM	0.29
7/2/2015	1:30:00 PM	0.29
7/2/2015	1:45:00 PM	0.29
7/2/2015	2:00:00 PM	0.29
7/2/2015	2:15:00 PM	0.29
7/2/2015	2:30:00 PM	0.29
7/2/2015	2:45:00 PM	0.29
7/2/2015	3:00:00 PM	0.29
7/2/2015	3:15:00 PM	0.29
7/2/2015	3:30:00 PM	0.29
7/2/2015	3:45:00 PM	0.29
7/2/2015	4:00:00 PM	0.29
7/2/2015	4:15:00 PM	0.29
7/2/2015	4:30:00 PM	0.29
7/2/2015	4:45:00 PM	0.29
7/2/2015	5:00:00 PM	0.29
7/2/2015	5:15:00 PM	0.29
7/2/2015	5:30:00 PM	0.29
7/2/2015	5:45:00 PM	0.29
7/2/2015	6:00:00 PM	0.29
7/2/2015	6:15:00 PM	0.29
7/2/2015	6:30:00 PM	0.29
7/2/2015	6:45:00 PM	0.29
7/2/2015	7:00:00 PM	0.29
7/2/2015	7:15:00 PM	0.29
7/2/2015	7:30:00 PM	0.29
7/2/2015	7:45:00 PM	0.29
7/2/2015	8:00:00 PM	0.29
7/2/2015	8:15:00 PM	0.3
7/2/2015	8:30:00 PM	0.3
7/2/2015	8:45:00 PM	0.3
7/2/2015	9:00:00 PM	0.3
7/2/2015	9:15:00 PM	0.3
7/2/2015	9:30:00 PM	0.3
7/2/2015	9:45:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
7/2/2015	10:00:00 PM	0.3
7/2/2015	10:15:00 PM	0.3
7/2/2015	10:30:00 PM	0.3
7/2/2015	10:45:00 PM	0.3
7/2/2015	11:00:00 PM	0.3
7/2/2015	11:15:00 PM	0.3
7/2/2015	11:30:00 PM	0.3
7/2/2015	11:45:00 PM	0.3
7/3/2015	12:00:00 AM	0.3
7/3/2015	12:15:00 AM	0.3
7/3/2015	12:30:00 AM	0.3
7/3/2015	12:45:00 AM	0.3
7/3/2015	1:00:00 AM	0.3
7/3/2015	1:15:00 AM	0.3
7/3/2015	1:30:00 AM	0.3
7/3/2015	1:45:00 AM	0.3
7/3/2015	2:00:00 AM	0.3
7/3/2015	2:15:00 AM	0.3
7/3/2015	2:30:00 AM	0.3
7/3/2015	2:45:00 AM	0.3
7/3/2015	3:00:00 AM	0.3
7/3/2015	3:15:00 AM	0.3
7/3/2015	3:30:00 AM	0.3
7/3/2015	3:45:00 AM	0.3
7/3/2015	4:00:00 AM	0.3
7/3/2015	4:15:00 AM	0.3
7/3/2015	4:30:00 AM	0.3
7/3/2015	4:45:00 AM	0.31
7/3/2015	5:00:00 AM	0.31
7/3/2015	5:15:00 AM	0.31
7/3/2015	5:30:00 AM	0.31
7/3/2015	5:45:00 AM	0.31
7/3/2015	6:00:00 AM	0.31
7/3/2015	6:15:00 AM	0.31
7/3/2015	6:30:00 AM	0.31
7/3/2015	6:45:00 AM	0.31
7/3/2015	7:00:00 AM	0.31
7/3/2015	7:15:00 AM	0.31
7/3/2015	7:30:00 AM	0.31
7/3/2015	7:45:00 AM	0.31
7/3/2015	8:00:00 AM	0.31
7/3/2015	8:15:00 AM	0.31
7/3/2015	8:30:00 AM	0.31
7/3/2015	8:45:00 AM	0.31
7/3/2015	9:00:00 AM	0.31
7/3/2015	9:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
7/3/2015	9:30:00 AM	0.31
7/3/2015	9:45:00 AM	0.31
7/3/2015	10:00:00 AM	0.31
7/3/2015	10:15:00 AM	0.31
7/3/2015	10:30:00 AM	0.31
7/3/2015	10:45:00 AM	0.31
7/3/2015	11:00:00 AM	0.31
7/3/2015	11:15:00 AM	0.31
7/3/2015	11:30:00 AM	0.31
7/3/2015	11:45:00 AM	0.31
7/3/2015	12:00:00 PM	0.31
7/3/2015	12:15:00 PM	0.31
7/3/2015	12:30:00 PM	0.31
7/3/2015	12:45:00 PM	0.31
7/3/2015	1:00:00 PM	0.31
7/3/2015	1:15:00 PM	0.31
7/3/2015	1:30:00 PM	0.31
7/3/2015	1:45:00 PM	0.31
7/3/2015	2:00:00 PM	0.31
7/3/2015	2:15:00 PM	0.31
7/3/2015	2:30:00 PM	0.31
7/3/2015	2:45:00 PM	0.31
7/3/2015	3:00:00 PM	0.31
7/3/2015	3:15:00 PM	0.31
7/3/2015	3:30:00 PM	0.31
7/3/2015	3:45:00 PM	0.31
7/3/2015	4:00:00 PM	0.31
7/3/2015	4:15:00 PM	0.31
7/3/2015	4:30:00 PM	0.31
7/3/2015	4:45:00 PM	0.31
7/3/2015	5:00:00 PM	0.31
7/3/2015	5:15:00 PM	0.31
7/3/2015	5:30:00 PM	0.31
7/3/2015	5:45:00 PM	0.31
7/3/2015	6:00:00 PM	0.31
7/3/2015	6:15:00 PM	0.31
7/3/2015	6:30:00 PM	0.31
7/3/2015	6:45:00 PM	0.31
7/3/2015	7:00:00 PM	0.31
7/3/2015	7:15:00 PM	0.31
7/3/2015	7:30:00 PM	0.31
7/3/2015	7:45:00 PM	0.31
7/3/2015	8:00:00 PM	0.31
7/3/2015	8:15:00 PM	0.31
7/3/2015	8:30:00 PM	0.31
7/3/2015	8:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
7/3/2015	9:00:00 PM	0.31
7/3/2015	9:15:00 PM	0.31
7/3/2015	9:30:00 PM	0.31
7/3/2015	9:45:00 PM	0.31
7/3/2015	10:00:00 PM	0.31
7/3/2015	10:15:00 PM	0.31
7/3/2015	10:30:00 PM	0.31
7/3/2015	10:45:00 PM	0.31
7/3/2015	11:00:00 PM	0.31
7/3/2015	11:15:00 PM	0.31
7/3/2015	11:30:00 PM	0.31
7/3/2015	11:45:00 PM	0.31
7/4/2015	12:00:00 AM	0.31
7/4/2015	12:15:00 AM	0.31
7/4/2015	12:30:00 AM	0.31
7/4/2015	12:45:00 AM	0.31
7/4/2015	1:00:00 AM	0.31
7/4/2015	1:15:00 AM	0.31
7/4/2015	1:30:00 AM	0.31
7/4/2015	1:45:00 AM	0.31
7/4/2015	2:00:00 AM	0.31
7/4/2015	2:15:00 AM	0.31
7/4/2015	2:30:00 AM	0.31
7/4/2015	2:45:00 AM	0.31
7/4/2015	3:00:00 AM	0.31
7/4/2015	3:15:00 AM	0.31
7/4/2015	3:30:00 AM	0.31
7/4/2015	3:45:00 AM	0.31
7/4/2015	4:00:00 AM	0.31
7/4/2015	4:15:00 AM	0.31
7/4/2015	4:30:00 AM	0.31
7/4/2015	4:45:00 AM	0.31
7/4/2015	5:00:00 AM	0.31
7/4/2015	5:15:00 AM	0.31
7/4/2015	5:30:00 AM	0.31
7/4/2015	5:45:00 AM	0.31
7/4/2015	6:00:00 AM	0.31
7/4/2015	6:15:00 AM	0.31
7/4/2015	6:30:00 AM	0.31
7/4/2015	6:45:00 AM	0.31
7/4/2015	7:00:00 AM	0.31
7/4/2015	7:15:00 AM	0.31
7/4/2015	7:30:00 AM	0.31
7/4/2015	7:45:00 AM	0.31
7/4/2015	8:00:00 AM	0.31
7/4/2015	8:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
7/4/2015	8:30:00 AM	0.31
7/4/2015	8:45:00 AM	0.31
7/4/2015	9:00:00 AM	0.31
7/4/2015	9:15:00 AM	0.31
7/4/2015	9:30:00 AM	0.31
7/4/2015	9:45:00 AM	0.31
7/4/2015	10:00:00 AM	0.31
7/4/2015	10:15:00 AM	0.31
7/4/2015	10:30:00 AM	0.31
7/4/2015	10:45:00 AM	0.31
7/4/2015	11:00:00 AM	0.31
7/4/2015	11:15:00 AM	0.31
7/4/2015	11:30:00 AM	0.31
7/4/2015	11:45:00 AM	0.31
7/4/2015	12:00:00 PM	0.31
7/4/2015	12:15:00 PM	0.31
7/4/2015	12:30:00 PM	0.31
7/4/2015	12:45:00 PM	0.31
7/4/2015	1:00:00 PM	0.31
7/4/2015	1:15:00 PM	0.31
7/4/2015	1:30:00 PM	0.31
7/4/2015	1:45:00 PM	0.31
7/4/2015	2:00:00 PM	0.31
7/4/2015	2:15:00 PM	0.31
7/4/2015	2:30:00 PM	0.31
7/4/2015	2:45:00 PM	0.31
7/4/2015	3:00:00 PM	0.31
7/4/2015	3:15:00 PM	0.31
7/4/2015	3:30:00 PM	0.31
7/4/2015	3:45:00 PM	0.31
7/4/2015	4:00:00 PM	0.31
7/4/2015	4:15:00 PM	0.31
7/4/2015	4:30:00 PM	0.31
7/4/2015	4:45:00 PM	0.31
7/4/2015	5:00:00 PM	0.31
7/4/2015	5:15:00 PM	0.31
7/4/2015	5:30:00 PM	0.31
7/4/2015	5:45:00 PM	0.31
7/4/2015	6:00:00 PM	0.31
7/4/2015	6:15:00 PM	0.31
7/4/2015	6:30:00 PM	0.31
7/4/2015	6:45:00 PM	0.31
7/4/2015	7:00:00 PM	0.31
7/4/2015	7:15:00 PM	0.31
7/4/2015	7:30:00 PM	0.31
7/4/2015	7:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
7/4/2015	8:00:00 PM	0.31
7/4/2015	8:15:00 PM	0.31
7/4/2015	8:30:00 PM	0.31
7/4/2015	8:45:00 PM	0.31
7/4/2015	9:00:00 PM	0.31
7/4/2015	9:15:00 PM	0.31
7/4/2015	9:30:00 PM	0.31
7/4/2015	9:45:00 PM	0.31
7/4/2015	10:00:00 PM	0.31
7/4/2015	10:15:00 PM	0.31
7/4/2015	10:30:00 PM	0.31
7/4/2015	10:45:00 PM	0.31
7/4/2015	11:00:00 PM	0.31
7/4/2015	11:15:00 PM	0.31
7/4/2015	11:30:00 PM	0.31
7/4/2015	11:45:00 PM	0.31
7/5/2015	12:00:00 AM	0.31
7/5/2015	12:15:00 AM	0.31
7/5/2015	12:30:00 AM	0.31
7/5/2015	12:45:00 AM	0.31
7/5/2015	1:00:00 AM	0.31
7/5/2015	1:15:00 AM	0.31
7/5/2015	1:30:00 AM	0.31
7/5/2015	1:45:00 AM	0.31
7/5/2015	2:00:00 AM	0.31
7/5/2015	2:15:00 AM	0.31
7/5/2015	2:30:00 AM	0.31
7/5/2015	2:45:00 AM	0.31
7/5/2015	3:00:00 AM	0.31
7/5/2015	3:15:00 AM	0.31
7/5/2015	3:30:00 AM	0.31
7/5/2015	3:45:00 AM	0.31
7/5/2015	4:00:00 AM	0.31
7/5/2015	4:15:00 AM	0.31
7/5/2015	4:30:00 AM	0.31
7/5/2015	4:45:00 AM	0.31
7/5/2015	5:00:00 AM	0.31
7/5/2015	5:15:00 AM	0.31
7/5/2015	5:30:00 AM	0.31
7/5/2015	5:45:00 AM	0.31
7/5/2015	6:00:00 AM	0.31
7/5/2015	6:15:00 AM	0.31
7/5/2015	6:30:00 AM	0.31
7/5/2015	6:45:00 AM	0.31
7/5/2015	7:00:00 AM	0.31
7/5/2015	7:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
7/5/2015	7:30:00 AM	0.31
7/5/2015	7:45:00 AM	0.31
7/5/2015	8:00:00 AM	0.31
7/5/2015	8:15:00 AM	0.31
7/5/2015	8:30:00 AM	0.31
7/5/2015	8:45:00 AM	0.31
7/5/2015	9:00:00 AM	0.31
7/5/2015	9:15:00 AM	0.31
7/5/2015	9:30:00 AM	0.31
7/5/2015	9:45:00 AM	0.31
7/5/2015	10:00:00 AM	0.31
7/5/2015	10:15:00 AM	0.31
7/5/2015	10:30:00 AM	0.31
7/5/2015	10:45:00 AM	0.31
7/5/2015	11:00:00 AM	0.31
7/5/2015	11:15:00 AM	0.31
7/5/2015	11:30:00 AM	0.31
7/5/2015	11:45:00 AM	0.31
7/5/2015	12:00:00 PM	0.31
7/5/2015	12:15:00 PM	0.31
7/5/2015	12:30:00 PM	0.31
7/5/2015	12:45:00 PM	0.31
7/5/2015	1:00:00 PM	0.31
7/5/2015	1:15:00 PM	0.31
7/5/2015	1:30:00 PM	0.31
7/5/2015	1:45:00 PM	0.31
7/5/2015	2:00:00 PM	0.31
7/5/2015	2:15:00 PM	0.31
7/5/2015	2:30:00 PM	0.31
7/5/2015	2:45:00 PM	0.31
7/5/2015	3:00:00 PM	0.31
7/5/2015	3:15:00 PM	0.31
7/5/2015	3:30:00 PM	0.31
7/5/2015	3:45:00 PM	0.31
7/5/2015	4:00:00 PM	0.31
7/5/2015	4:15:00 PM	0.31
7/5/2015	4:30:00 PM	0.31
7/5/2015	4:45:00 PM	0.31
7/5/2015	5:00:00 PM	0.31
7/5/2015	5:15:00 PM	0.31
7/5/2015	5:30:00 PM	0.31
7/5/2015	5:45:00 PM	0.31
7/5/2015	6:00:00 PM	0.31
7/5/2015	6:15:00 PM	0.31
7/5/2015	6:30:00 PM	0.31
7/5/2015	6:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
7/5/2015	7:00:00 PM	0.31
7/5/2015	7:15:00 PM	0.31
7/5/2015	7:30:00 PM	0.31
7/5/2015	7:45:00 PM	0.31
7/5/2015	8:00:00 PM	0.31
7/5/2015	8:15:00 PM	0.31
7/5/2015	8:30:00 PM	0.31
7/5/2015	8:45:00 PM	0.31
7/5/2015	9:00:00 PM	0.31
7/5/2015	9:15:00 PM	0.31
7/5/2015	9:30:00 PM	0.31
7/5/2015	9:45:00 PM	0.31
7/5/2015	10:00:00 PM	0.31
7/5/2015	10:15:00 PM	0.31
7/5/2015	10:30:00 PM	0.31
7/5/2015	10:45:00 PM	0.31
7/5/2015	11:00:00 PM	0.31
7/5/2015	11:15:00 PM	0.31
7/5/2015	11:30:00 PM	0.31
7/5/2015	11:45:00 PM	0.31
7/6/2015	12:00:00 AM	0.31
7/6/2015	12:15:00 AM	0.31
7/6/2015	12:30:00 AM	0.31
7/6/2015	12:45:00 AM	0.31
7/6/2015	1:00:00 AM	0.31
7/6/2015	1:15:00 AM	0.31
7/6/2015	1:30:00 AM	0.31
7/6/2015	1:45:00 AM	0.31
7/6/2015	2:00:00 AM	0.31
7/6/2015	2:15:00 AM	0.31
7/6/2015	2:30:00 AM	0.31
7/6/2015	2:45:00 AM	0.31
7/6/2015	3:00:00 AM	0.31
7/6/2015	3:15:00 AM	0.31
7/6/2015	3:30:00 AM	0.31
7/6/2015	3:45:00 AM	0.31
7/6/2015	4:00:00 AM	0.31
7/6/2015	4:15:00 AM	0.31
7/6/2015	4:30:00 AM	0.31
7/6/2015	4:45:00 AM	0.31
7/6/2015	5:00:00 AM	0.31
7/6/2015	5:15:00 AM	0.31
7/6/2015	5:30:00 AM	0.31
7/6/2015	5:45:00 AM	0.31
7/6/2015	6:00:00 AM	0.31
7/6/2015	6:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
7/6/2015	6:30:00 AM	0.31
7/6/2015	6:45:00 AM	0.31
7/6/2015	7:00:00 AM	0.31
7/6/2015	7:15:00 AM	0.31
7/6/2015	7:30:00 AM	0.31
7/6/2015	7:45:00 AM	0.31
7/6/2015	8:00:00 AM	0.31
7/6/2015	8:15:00 AM	0.31
7/6/2015	8:30:00 AM	0.31
7/6/2015	8:45:00 AM	0.31
7/6/2015	9:00:00 AM	0.31
7/6/2015	9:15:00 AM	0.31
7/6/2015	9:30:00 AM	0.31
7/6/2015	9:45:00 AM	0.32
7/6/2015	10:00:00 AM	0.32
7/6/2015	10:15:00 AM	0.32
7/6/2015	10:30:00 AM	0.32
7/6/2015	10:45:00 AM	0.32
7/6/2015	11:00:00 AM	0.32
7/6/2015	11:15:00 AM	0.32
7/6/2015	11:30:00 AM	0.32
7/6/2015	11:45:00 AM	0.32
7/6/2015	12:00:00 PM	0.32
7/6/2015	12:15:00 PM	0.32
7/6/2015	12:30:00 PM	0.32
7/6/2015	12:45:00 PM	0.32
7/6/2015	1:00:00 PM	0.32
7/6/2015	1:15:00 PM	0.32
7/6/2015	1:30:00 PM	0.32
7/6/2015	1:45:00 PM	0.32
7/6/2015	2:00:00 PM	0.32
7/6/2015	2:15:00 PM	0.31
7/6/2015	2:30:00 PM	0.31
7/6/2015	2:45:00 PM	0.31
7/6/2015	3:00:00 PM	0.31
7/6/2015	3:15:00 PM	0.31
7/6/2015	3:30:00 PM	0.31
7/6/2015	3:45:00 PM	0.31
7/6/2015	4:00:00 PM	0.31
7/6/2015	4:15:00 PM	0.31
7/6/2015	4:30:00 PM	0.31
7/6/2015	4:45:00 PM	0.31
7/6/2015	5:00:00 PM	0.31
7/6/2015	5:15:00 PM	0.31
7/6/2015	5:30:00 PM	0.31
7/6/2015	5:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
7/6/2015	6:00:00 PM	0.31
7/6/2015	6:15:00 PM	0.31
7/6/2015	6:30:00 PM	0.31
7/6/2015	6:45:00 PM	0.31
7/6/2015	7:00:00 PM	0.31
7/6/2015	7:15:00 PM	0.31
7/6/2015	7:30:00 PM	0.31
7/6/2015	7:45:00 PM	0.31
7/6/2015	8:00:00 PM	0.31
7/6/2015	8:15:00 PM	0.31
7/6/2015	8:30:00 PM	0.31
7/6/2015	8:45:00 PM	0.32
7/6/2015	9:00:00 PM	0.32
7/6/2015	9:15:00 PM	0.32
7/6/2015	9:30:00 PM	0.32
7/6/2015	9:45:00 PM	0.32
7/6/2015	10:00:00 PM	0.32
7/6/2015	10:15:00 PM	0.32
7/6/2015	10:30:00 PM	0.32
7/6/2015	10:45:00 PM	0.32
7/6/2015	11:00:00 PM	0.32
7/6/2015	11:15:00 PM	0.32
7/6/2015	11:30:00 PM	0.32
7/6/2015	11:45:00 PM	0.32
7/7/2015	12:00:00 AM	0.32
7/7/2015	12:15:00 AM	0.32
7/7/2015	12:30:00 AM	0.32
7/7/2015	12:45:00 AM	0.32
7/7/2015	1:00:00 AM	0.32
7/7/2015	1:15:00 AM	0.32
7/7/2015	1:30:00 AM	0.32
7/7/2015	1:45:00 AM	0.32
7/7/2015	2:00:00 AM	0.32
7/7/2015	2:15:00 AM	0.32
7/7/2015	2:30:00 AM	0.32
7/7/2015	2:45:00 AM	0.32
7/7/2015	3:00:00 AM	0.32
7/7/2015	3:15:00 AM	0.32
7/7/2015	3:30:00 AM	0.32
7/7/2015	3:45:00 AM	0.32
7/7/2015	4:00:00 AM	0.32
7/7/2015	4:15:00 AM	0.32
7/7/2015	4:30:00 AM	0.32
7/7/2015	4:45:00 AM	0.32
7/7/2015	5:00:00 AM	0.32
7/7/2015	5:15:00 AM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
7/7/2015	5:30:00 AM	0.32
7/7/2015	5:45:00 AM	0.32
7/7/2015	6:00:00 AM	0.32
7/7/2015	6:15:00 AM	0.32
7/7/2015	6:30:00 AM	0.32
7/7/2015	6:45:00 AM	0.32
7/7/2015	7:00:00 AM	0.32
7/7/2015	7:15:00 AM	0.32
7/7/2015	7:30:00 AM	0.32
7/7/2015	7:45:00 AM	0.32
7/7/2015	8:00:00 AM	0.32
7/7/2015	8:15:00 AM	0.32
7/7/2015	8:30:00 AM	0.32
7/7/2015	8:45:00 AM	0.32
7/7/2015	9:00:00 AM	0.32
7/7/2015	9:15:00 AM	0.32
7/7/2015	9:30:00 AM	0.32
7/7/2015	9:45:00 AM	0.32
7/7/2015	10:00:00 AM	0.32
7/7/2015	10:15:00 AM	0.32
7/7/2015	10:30:00 AM	0.32
7/7/2015	10:45:00 AM	0.32
7/7/2015	11:00:00 AM	0.32
7/7/2015	11:15:00 AM	0.32
7/7/2015	11:30:00 AM	0.32
7/7/2015	11:45:00 AM	0.32
7/7/2015	12:00:00 PM	0.32
7/7/2015	12:15:00 PM	0.32
7/7/2015	12:30:00 PM	0.32
7/7/2015	12:45:00 PM	0.32
7/7/2015	1:00:00 PM	0.32
7/7/2015	1:15:00 PM	0.32
7/7/2015	1:30:00 PM	0.32
7/7/2015	1:45:00 PM	0.32
7/7/2015	2:00:00 PM	0.32
7/7/2015	2:15:00 PM	0.32
7/7/2015	2:30:00 PM	0.32
7/7/2015	2:45:00 PM	0.32
7/7/2015	3:00:00 PM	0.32
7/7/2015	3:15:00 PM	0.32
7/7/2015	3:30:00 PM	0.32
7/7/2015	3:45:00 PM	0.32
7/7/2015	4:00:00 PM	0.32
7/7/2015	4:15:00 PM	0.32
7/7/2015	4:30:00 PM	0.32
7/7/2015	4:45:00 PM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
7/7/2015	5:00:00 PM	0.32
7/7/2015	5:15:00 PM	0.32
7/7/2015	5:30:00 PM	0.32
7/7/2015	5:45:00 PM	0.32
7/7/2015	6:00:00 PM	0.32
7/7/2015	6:15:00 PM	0.32
7/7/2015	6:30:00 PM	0.32
7/7/2015	6:45:00 PM	0.32
7/7/2015	7:00:00 PM	0.32
7/7/2015	7:15:00 PM	0.32
7/7/2015	7:30:00 PM	0.32
7/7/2015	7:45:00 PM	0.32
7/7/2015	8:00:00 PM	0.32
7/7/2015	8:15:00 PM	0.32
7/7/2015	8:30:00 PM	0.32
7/7/2015	8:45:00 PM	0.32
7/7/2015	9:00:00 PM	0.32
7/7/2015	9:15:00 PM	0.32
7/7/2015	9:30:00 PM	0.32
7/7/2015	9:45:00 PM	0.32
7/7/2015	10:00:00 PM	0.32
7/7/2015	10:15:00 PM	0.32
7/7/2015	10:30:00 PM	0.32
7/7/2015	10:45:00 PM	0.32
7/7/2015	11:00:00 PM	0.32
7/7/2015	11:15:00 PM	0.32
7/7/2015	11:30:00 PM	0.32
7/7/2015	11:45:00 PM	0.32
7/8/2015	12:00:00 AM	0.32
7/8/2015	12:15:00 AM	0.32
7/8/2015	12:30:00 AM	0.32
7/8/2015	12:45:00 AM	0.32
7/8/2015	1:00:00 AM	0.32
7/8/2015	1:15:00 AM	0.32
7/8/2015	1:30:00 AM	0.32
7/8/2015	1:45:00 AM	0.32
7/8/2015	2:00:00 AM	0.32
7/8/2015	2:15:00 AM	0.32
7/8/2015	2:30:00 AM	0.32
7/8/2015	2:45:00 AM	0.32
7/8/2015	3:00:00 AM	0.32
7/8/2015	3:15:00 AM	0.32
7/8/2015	3:30:00 AM	0.32
7/8/2015	3:45:00 AM	0.32
7/8/2015	4:00:00 AM	0.32
7/8/2015	4:15:00 AM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
7/8/2015	4:30:00 AM	0.32
7/8/2015	4:45:00 AM	0.32
7/8/2015	5:00:00 AM	0.32
7/8/2015	5:15:00 AM	0.32
7/8/2015	5:30:00 AM	0.32
7/8/2015	5:45:00 AM	0.32
7/8/2015	6:00:00 AM	0.32
7/8/2015	6:15:00 AM	0.32
7/8/2015	6:30:00 AM	0.32
7/8/2015	6:45:00 AM	0.32
7/8/2015	7:00:00 AM	0.32
7/8/2015	7:15:00 AM	0.32
7/8/2015	7:30:00 AM	0.32
7/8/2015	7:45:00 AM	0.32
7/8/2015	8:00:00 AM	0.32
7/8/2015	8:15:00 AM	0.32
7/8/2015	8:30:00 AM	0.32
7/8/2015	8:45:00 AM	0.32
7/8/2015	9:00:00 AM	0.32
7/8/2015	9:15:00 AM	0.32
7/8/2015	9:30:00 AM	0.33
7/8/2015	9:45:00 AM	0.33
7/8/2015	10:00:00 AM	0.33
7/8/2015	10:15:00 AM	0.33
7/8/2015	10:30:00 AM	0.33
7/8/2015	10:45:00 AM	0.33
7/8/2015	11:00:00 AM	0.33
7/8/2015	11:15:00 AM	0.33
7/8/2015	11:30:00 AM	0.33
7/8/2015	11:45:00 AM	0.33
7/8/2015	12:00:00 PM	0.33
7/8/2015	12:15:00 PM	0.33
7/8/2015	12:30:00 PM	0.33
7/8/2015	12:45:00 PM	0.33
7/8/2015	1:00:00 PM	0.33
7/8/2015	1:15:00 PM	0.33
7/8/2015	1:30:00 PM	0.33
7/8/2015	1:45:00 PM	0.33
7/8/2015	2:00:00 PM	0.33
7/8/2015	2:15:00 PM	0.33
7/8/2015	2:30:00 PM	0.33
7/8/2015	2:45:00 PM	0.33
7/8/2015	3:00:00 PM	0.32
7/8/2015	3:15:00 PM	0.32
7/8/2015	3:30:00 PM	0.32
7/8/2015	3:45:00 PM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
7/8/2015	4:00:00 PM	0.32
7/8/2015	4:15:00 PM	0.32
7/8/2015	4:30:00 PM	0.32
7/8/2015	4:45:00 PM	0.32
7/8/2015	5:00:00 PM	0.32
7/8/2015	5:15:00 PM	0.32
7/8/2015	5:30:00 PM	0.32
7/8/2015	5:45:00 PM	0.32
7/8/2015	6:00:00 PM	0.32
7/8/2015	6:15:00 PM	0.32
7/8/2015	6:30:00 PM	0.32
7/8/2015	6:45:00 PM	0.32
7/8/2015	7:00:00 PM	0.32
7/8/2015	7:15:00 PM	0.32
7/8/2015	7:30:00 PM	0.32
7/8/2015	7:45:00 PM	0.32
7/8/2015	8:00:00 PM	0.32
7/8/2015	8:15:00 PM	0.32
7/8/2015	8:30:00 PM	0.32
7/8/2015	8:45:00 PM	0.32
7/8/2015	9:00:00 PM	0.32
7/8/2015	9:15:00 PM	0.32
7/8/2015	9:30:00 PM	0.32
7/8/2015	9:45:00 PM	0.32
7/8/2015	10:00:00 PM	0.32
7/8/2015	10:15:00 PM	0.32
7/8/2015	10:30:00 PM	0.32
7/8/2015	10:45:00 PM	0.32
7/8/2015	11:00:00 PM	0.32
7/8/2015	11:15:00 PM	0.32
7/8/2015	11:30:00 PM	0.32
7/8/2015	11:45:00 PM	0.32
7/9/2015	12:00:00 AM	0.32
7/9/2015	12:15:00 AM	0.32
7/9/2015	12:30:00 AM	0.32
7/9/2015	12:45:00 AM	0.32
7/9/2015	1:00:00 AM	0.32
7/9/2015	1:15:00 AM	0.32
7/9/2015	1:30:00 AM	0.32
7/9/2015	1:45:00 AM	0.32
7/9/2015	2:00:00 AM	0.32
7/9/2015	2:15:00 AM	0.32
7/9/2015	2:30:00 AM	0.32
7/9/2015	2:45:00 AM	0.32
7/9/2015	3:00:00 AM	0.32
7/9/2015	3:15:00 AM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
7/9/2015	3:30:00 AM	0.32
7/9/2015	3:45:00 AM	0.32
7/9/2015	4:00:00 AM	0.32
7/9/2015	4:15:00 AM	0.32
7/9/2015	4:30:00 AM	0.32
7/9/2015	4:45:00 AM	0.32
7/9/2015	5:00:00 AM	0.32
7/9/2015	5:15:00 AM	0.32
7/9/2015	5:30:00 AM	0.32
7/9/2015	5:45:00 AM	0.32
7/9/2015	6:00:00 AM	0.32
7/9/2015	6:15:00 AM	0.32
7/9/2015	6:30:00 AM	0.32
7/9/2015	6:45:00 AM	0.32
7/9/2015	7:00:00 AM	0.32
7/9/2015	7:15:00 AM	0.32
7/9/2015	7:30:00 AM	0.32
7/9/2015	7:45:00 AM	0.32
7/9/2015	8:00:00 AM	0.32
7/9/2015	8:15:00 AM	0.32
7/9/2015	8:30:00 AM	0.32
7/9/2015	8:45:00 AM	0.32
7/9/2015	9:00:00 AM	0.32
7/9/2015	9:15:00 AM	0.32
7/9/2015	9:30:00 AM	0.32
7/9/2015	9:45:00 AM	0.32
7/9/2015	10:00:00 AM	0.32
7/9/2015	10:15:00 AM	0.32
7/9/2015	10:30:00 AM	0.32
7/9/2015	10:45:00 AM	0.32
7/9/2015	11:00:00 AM	0.32
7/9/2015	11:15:00 AM	0.32
7/9/2015	11:30:00 AM	0.32
7/9/2015	11:45:00 AM	0.32
7/9/2015	12:00:00 PM	0.32
7/9/2015	12:15:00 PM	0.32
7/9/2015	12:30:00 PM	0.32
7/9/2015	12:45:00 PM	0.32
7/9/2015	1:00:00 PM	0.32
7/9/2015	1:15:00 PM	0.32
7/9/2015	1:30:00 PM	0.32
7/9/2015	1:45:00 PM	0.32
7/9/2015	2:00:00 PM	0.32
7/9/2015	2:15:00 PM	0.32
7/9/2015	2:30:00 PM	0.32
7/9/2015	2:45:00 PM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
7/9/2015	3:00:00 PM	0.32
7/9/2015	3:15:00 PM	0.32
7/9/2015	3:30:00 PM	0.32
7/9/2015	3:45:00 PM	0.32
7/9/2015	4:00:00 PM	0.32
7/9/2015	4:15:00 PM	0.32
7/9/2015	4:30:00 PM	0.32
7/9/2015	4:45:00 PM	0.32
7/9/2015	5:00:00 PM	0.32
7/9/2015	5:15:00 PM	0.32
7/9/2015	5:30:00 PM	0.32
7/9/2015	5:45:00 PM	0.32
7/9/2015	6:00:00 PM	0.32
7/9/2015	6:15:00 PM	0.32
7/9/2015	6:30:00 PM	0.32
7/9/2015	6:45:00 PM	0.32
7/9/2015	7:00:00 PM	0.32
7/9/2015	7:15:00 PM	0.32
7/9/2015	7:30:00 PM	0.32
7/9/2015	7:45:00 PM	0.32
7/9/2015	8:00:00 PM	0.32
7/9/2015	8:15:00 PM	0.32
7/9/2015	8:30:00 PM	0.32
7/9/2015	8:45:00 PM	0.32
7/9/2015	9:00:00 PM	0.32
7/9/2015	9:15:00 PM	0.32
7/9/2015	9:30:00 PM	0.32
7/9/2015	9:45:00 PM	0.32
7/9/2015	10:00:00 PM	0.32
7/9/2015	10:15:00 PM	0.32
7/9/2015	10:30:00 PM	0.32
7/9/2015	10:45:00 PM	0.32
7/9/2015	11:00:00 PM	0.32
7/9/2015	11:15:00 PM	0.32
7/9/2015	11:30:00 PM	0.32
7/9/2015	11:45:00 PM	0.32
7/10/2015	12:00:00 AM	0.32
7/10/2015	12:15:00 AM	0.32
7/10/2015	12:30:00 AM	0.32
7/10/2015	12:45:00 AM	0.32
7/10/2015	1:00:00 AM	0.32
7/10/2015	1:15:00 AM	0.32
7/10/2015	1:30:00 AM	0.32
7/10/2015	1:45:00 AM	0.32
7/10/2015	2:00:00 AM	0.32
7/10/2015	2:15:00 AM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
7/10/2015	2:30:00 AM	0.32
7/10/2015	2:45:00 AM	0.32
7/10/2015	3:00:00 AM	0.32
7/10/2015	3:15:00 AM	0.32
7/10/2015	3:30:00 AM	0.32
7/10/2015	3:45:00 AM	0.32
7/10/2015	4:00:00 AM	0.32
7/10/2015	4:15:00 AM	0.32
7/10/2015	4:30:00 AM	0.32
7/10/2015	4:45:00 AM	0.32
7/10/2015	5:00:00 AM	0.32
7/10/2015	5:15:00 AM	0.32
7/10/2015	5:30:00 AM	0.32
7/10/2015	5:45:00 AM	0.32
7/10/2015	6:00:00 AM	0.32
7/10/2015	6:15:00 AM	0.32
7/10/2015	6:30:00 AM	0.32
7/10/2015	6:45:00 AM	0.32
7/10/2015	7:00:00 AM	0.32
7/10/2015	7:15:00 AM	0.32
7/10/2015	7:30:00 AM	0.32
7/10/2015	7:45:00 AM	0.32
7/10/2015	8:00:00 AM	0.32
7/10/2015	8:15:00 AM	0.32
7/10/2015	8:30:00 AM	0.32
7/10/2015	8:45:00 AM	0.32
7/10/2015	9:00:00 AM	0.32
7/10/2015	9:15:00 AM	0.32
7/10/2015	9:30:00 AM	0.32
7/10/2015	9:45:00 AM	0.32
7/10/2015	10:00:00 AM	0.32
7/10/2015	10:15:00 AM	0.32
7/10/2015	10:30:00 AM	0.32
7/10/2015	10:45:00 AM	0.32
7/10/2015	11:00:00 AM	0.32
7/10/2015	11:15:00 AM	0.32
7/10/2015	11:30:00 AM	0.32
7/10/2015	11:45:00 AM	0.32
7/10/2015	12:00:00 PM	0.32
7/10/2015	12:15:00 PM	0.32
7/10/2015	12:30:00 PM	0.32
7/10/2015	12:45:00 PM	0.32
7/10/2015	1:00:00 PM	0.32
7/10/2015	1:15:00 PM	0.32
7/10/2015	1:30:00 PM	0.32
7/10/2015	1:45:00 PM	0.32

Billy Lake Return Gage

DATE	TIME	GAGE
7/10/2015	2:00:00 PM	0.32
7/10/2015	2:15:00 PM	0.31
7/10/2015	2:30:00 PM	0.31
7/10/2015	2:45:00 PM	0.31
7/10/2015	3:00:00 PM	0.31
7/10/2015	3:15:00 PM	0.31
7/10/2015	3:30:00 PM	0.31
7/10/2015	3:45:00 PM	0.31
7/10/2015	4:00:00 PM	0.31
7/10/2015	4:15:00 PM	0.31
7/10/2015	4:30:00 PM	0.31
7/10/2015	4:45:00 PM	0.31
7/10/2015	5:00:00 PM	0.31
7/10/2015	5:15:00 PM	0.31
7/10/2015	5:30:00 PM	0.31
7/10/2015	5:45:00 PM	0.31
7/10/2015	6:00:00 PM	0.31
7/10/2015	6:15:00 PM	0.31
7/10/2015	6:30:00 PM	0.31
7/10/2015	6:45:00 PM	0.31
7/10/2015	7:00:00 PM	0.31
7/10/2015	7:15:00 PM	0.31
7/10/2015	7:30:00 PM	0.31
7/10/2015	7:45:00 PM	0.31
7/10/2015	8:00:00 PM	0.31
7/10/2015	8:15:00 PM	0.31
7/10/2015	8:30:00 PM	0.31
7/10/2015	8:45:00 PM	0.31
7/10/2015	9:00:00 PM	0.31
7/10/2015	9:15:00 PM	0.31
7/10/2015	9:30:00 PM	0.31
7/10/2015	9:45:00 PM	0.31
7/10/2015	10:00:00 PM	0.31
7/10/2015	10:15:00 PM	0.31
7/10/2015	10:30:00 PM	0.31
7/10/2015	10:45:00 PM	0.31
7/10/2015	11:00:00 PM	0.31
7/10/2015	11:15:00 PM	0.31
7/10/2015	11:30:00 PM	0.31
7/10/2015	11:45:00 PM	0.31
7/11/2015	12:00:00 AM	0.31
7/11/2015	12:15:00 AM	0.31
7/11/2015	12:30:00 AM	0.31
7/11/2015	12:45:00 AM	0.31
7/11/2015	1:00:00 AM	0.31
7/11/2015	1:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
7/11/2015	1:30:00 AM	0.31
7/11/2015	1:45:00 AM	0.31
7/11/2015	2:00:00 AM	0.31
7/11/2015	2:15:00 AM	0.31
7/11/2015	2:30:00 AM	0.31
7/11/2015	2:45:00 AM	0.31
7/11/2015	3:00:00 AM	0.31
7/11/2015	3:15:00 AM	0.31
7/11/2015	3:30:00 AM	0.31
7/11/2015	3:45:00 AM	0.31
7/11/2015	4:00:00 AM	0.31
7/11/2015	4:15:00 AM	0.31
7/11/2015	4:30:00 AM	0.31
7/11/2015	4:45:00 AM	0.31
7/11/2015	5:00:00 AM	0.31
7/11/2015	5:15:00 AM	0.31
7/11/2015	5:30:00 AM	0.31
7/11/2015	5:45:00 AM	0.31
7/11/2015	6:00:00 AM	0.31
7/11/2015	6:15:00 AM	0.31
7/11/2015	6:30:00 AM	0.31
7/11/2015	6:45:00 AM	0.31
7/11/2015	7:00:00 AM	0.31
7/11/2015	7:15:00 AM	0.31
7/11/2015	7:30:00 AM	0.31
7/11/2015	7:45:00 AM	0.31
7/11/2015	8:00:00 AM	0.31
7/11/2015	8:15:00 AM	0.31
7/11/2015	8:30:00 AM	0.31
7/11/2015	8:45:00 AM	0.31
7/11/2015	9:00:00 AM	0.31
7/11/2015	9:15:00 AM	0.31
7/11/2015	9:30:00 AM	0.31
7/11/2015	9:45:00 AM	0.31
7/11/2015	10:00:00 AM	0.31
7/11/2015	10:15:00 AM	0.31
7/11/2015	10:30:00 AM	0.31
7/11/2015	10:45:00 AM	0.31
7/11/2015	11:00:00 AM	0.31
7/11/2015	11:15:00 AM	0.31
7/11/2015	11:30:00 AM	0.31
7/11/2015	11:45:00 AM	0.31
7/11/2015	12:00:00 PM	0.31
7/11/2015	12:15:00 PM	0.31
7/11/2015	12:30:00 PM	0.31
7/11/2015	12:45:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
7/11/2015	1:00:00 PM	0.31
7/11/2015	1:15:00 PM	0.31
7/11/2015	1:30:00 PM	0.31
7/11/2015	1:45:00 PM	0.31
7/11/2015	2:00:00 PM	0.31
7/11/2015	2:15:00 PM	0.31
7/11/2015	2:30:00 PM	0.31
7/11/2015	2:45:00 PM	0.31
7/11/2015	3:00:00 PM	0.31
7/11/2015	3:15:00 PM	0.31
7/11/2015	3:30:00 PM	0.31
7/11/2015	3:45:00 PM	0.31
7/11/2015	4:00:00 PM	0.31
7/11/2015	4:15:00 PM	0.31
7/11/2015	4:30:00 PM	0.31
7/11/2015	4:45:00 PM	0.31
7/11/2015	5:00:00 PM	0.31
7/11/2015	5:15:00 PM	0.31
7/11/2015	5:30:00 PM	0.31
7/11/2015	5:45:00 PM	0.31
7/11/2015	6:00:00 PM	0.31
7/11/2015	6:15:00 PM	0.31
7/11/2015	6:30:00 PM	0.31
7/11/2015	6:45:00 PM	0.31
7/11/2015	7:00:00 PM	0.31
7/11/2015	7:15:00 PM	0.31
7/11/2015	7:30:00 PM	0.31
7/11/2015	7:45:00 PM	0.31
7/11/2015	8:00:00 PM	0.31
7/11/2015	8:15:00 PM	0.31
7/11/2015	8:30:00 PM	0.31
7/11/2015	8:45:00 PM	0.31
7/11/2015	9:00:00 PM	0.31
7/11/2015	9:15:00 PM	0.31
7/11/2015	9:30:00 PM	0.31
7/11/2015	9:45:00 PM	0.31
7/11/2015	10:00:00 PM	0.31
7/11/2015	10:15:00 PM	0.31
7/11/2015	10:30:00 PM	0.31
7/11/2015	10:45:00 PM	0.31
7/11/2015	11:00:00 PM	0.31
7/11/2015	11:15:00 PM	0.31
7/11/2015	11:30:00 PM	0.31
7/11/2015	11:45:00 PM	0.31
7/12/2015	12:00:00 AM	0.31
7/12/2015	12:15:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
7/12/2015	12:30:00 AM	0.31
7/12/2015	12:45:00 AM	0.31
7/12/2015	1:00:00 AM	0.31
7/12/2015	1:15:00 AM	0.31
7/12/2015	1:30:00 AM	0.31
7/12/2015	1:45:00 AM	0.31
7/12/2015	2:00:00 AM	0.31
7/12/2015	2:15:00 AM	0.31
7/12/2015	2:30:00 AM	0.31
7/12/2015	2:45:00 AM	0.31
7/12/2015	3:00:00 AM	0.31
7/12/2015	3:15:00 AM	0.31
7/12/2015	3:30:00 AM	0.31
7/12/2015	3:45:00 AM	0.31
7/12/2015	4:00:00 AM	0.31
7/12/2015	4:15:00 AM	0.31
7/12/2015	4:30:00 AM	0.31
7/12/2015	4:45:00 AM	0.31
7/12/2015	5:00:00 AM	0.31
7/12/2015	5:15:00 AM	0.31
7/12/2015	5:30:00 AM	0.31
7/12/2015	5:45:00 AM	0.31
7/12/2015	6:00:00 AM	0.31
7/12/2015	6:15:00 AM	0.31
7/12/2015	6:30:00 AM	0.31
7/12/2015	6:45:00 AM	0.31
7/12/2015	7:00:00 AM	0.31
7/12/2015	7:15:00 AM	0.31
7/12/2015	7:30:00 AM	0.31
7/12/2015	7:45:00 AM	0.31
7/12/2015	8:00:00 AM	0.31
7/12/2015	8:15:00 AM	0.31
7/12/2015	8:30:00 AM	0.31
7/12/2015	8:45:00 AM	0.31
7/12/2015	9:00:00 AM	0.31
7/12/2015	9:15:00 AM	0.31
7/12/2015	9:30:00 AM	0.31
7/12/2015	9:45:00 AM	0.31
7/12/2015	10:00:00 AM	0.31
7/12/2015	10:15:00 AM	0.31
7/12/2015	10:30:00 AM	0.31
7/12/2015	10:45:00 AM	0.31
7/12/2015	11:00:00 AM	0.31
7/12/2015	11:15:00 AM	0.31
7/12/2015	11:30:00 AM	0.31
7/12/2015	11:45:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
7/12/2015	12:00:00 PM	0.31
7/12/2015	12:15:00 PM	0.31
7/12/2015	12:30:00 PM	0.31
7/12/2015	12:45:00 PM	0.31
7/12/2015	1:00:00 PM	0.31
7/12/2015	1:15:00 PM	0.31
7/12/2015	1:30:00 PM	0.31
7/12/2015	1:45:00 PM	0.31
7/12/2015	2:00:00 PM	0.31
7/12/2015	2:15:00 PM	0.31
7/12/2015	2:30:00 PM	0.31
7/12/2015	2:45:00 PM	0.31
7/12/2015	3:00:00 PM	0.31
7/12/2015	3:15:00 PM	0.31
7/12/2015	3:30:00 PM	0.31
7/12/2015	3:45:00 PM	0.31
7/12/2015	4:00:00 PM	0.31
7/12/2015	4:15:00 PM	0.31
7/12/2015	4:30:00 PM	0.31
7/12/2015	4:45:00 PM	0.31
7/12/2015	5:00:00 PM	0.31
7/12/2015	5:15:00 PM	0.31
7/12/2015	5:30:00 PM	0.31
7/12/2015	5:45:00 PM	0.31
7/12/2015	6:00:00 PM	0.31
7/12/2015	6:15:00 PM	0.31
7/12/2015	6:30:00 PM	0.31
7/12/2015	6:45:00 PM	0.31
7/12/2015	7:00:00 PM	0.31
7/12/2015	7:15:00 PM	0.31
7/12/2015	7:30:00 PM	0.31
7/12/2015	7:45:00 PM	0.31
7/12/2015	8:00:00 PM	0.31
7/12/2015	8:15:00 PM	0.31
7/12/2015	8:30:00 PM	0.31
7/12/2015	8:45:00 PM	0.31
7/12/2015	9:00:00 PM	0.31
7/12/2015	9:15:00 PM	0.31
7/12/2015	9:30:00 PM	0.31
7/12/2015	9:45:00 PM	0.31
7/12/2015	10:00:00 PM	0.31
7/12/2015	10:15:00 PM	0.31
7/12/2015	10:30:00 PM	0.31
7/12/2015	10:45:00 PM	0.31
7/12/2015	11:00:00 PM	0.31
7/12/2015	11:15:00 PM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
7/12/2015	11:30:00 PM	0.31
7/12/2015	11:45:00 PM	0.31
7/13/2015	12:00:00 AM	0.31
7/13/2015	12:15:00 AM	0.31
7/13/2015	12:30:00 AM	0.31
7/13/2015	12:45:00 AM	0.31
7/13/2015	1:00:00 AM	0.31
7/13/2015	1:15:00 AM	0.31
7/13/2015	1:30:00 AM	0.31
7/13/2015	1:45:00 AM	0.31
7/13/2015	2:00:00 AM	0.31
7/13/2015	2:15:00 AM	0.31
7/13/2015	2:30:00 AM	0.31
7/13/2015	2:45:00 AM	0.31
7/13/2015	3:00:00 AM	0.31
7/13/2015	3:15:00 AM	0.31
7/13/2015	3:30:00 AM	0.31
7/13/2015	3:45:00 AM	0.31
7/13/2015	4:00:00 AM	0.31
7/13/2015	4:15:00 AM	0.31
7/13/2015	4:30:00 AM	0.31
7/13/2015	4:45:00 AM	0.31
7/13/2015	5:00:00 AM	0.31
7/13/2015	5:15:00 AM	0.31
7/13/2015	5:30:00 AM	0.31
7/13/2015	5:45:00 AM	0.31
7/13/2015	6:00:00 AM	0.31
7/13/2015	6:15:00 AM	0.31
7/13/2015	6:30:00 AM	0.31
7/13/2015	6:45:00 AM	0.31
7/13/2015	7:00:00 AM	0.31
7/13/2015	7:15:00 AM	0.31
7/13/2015	7:30:00 AM	0.31
7/13/2015	7:45:00 AM	0.31
7/13/2015	8:00:00 AM	0.31
7/13/2015	8:15:00 AM	0.31
7/13/2015	8:30:00 AM	0.31
7/13/2015	8:45:00 AM	0.31
7/13/2015	9:00:00 AM	0.31
7/13/2015	9:15:00 AM	0.31
7/13/2015	9:30:00 AM	0.31
7/13/2015	9:45:00 AM	0.31
7/13/2015	10:00:00 AM	0.31
7/13/2015	10:15:00 AM	0.31
7/13/2015	10:30:00 AM	0.31
7/13/2015	10:45:00 AM	0.31

Billy Lake Return Gage

DATE	TIME	GAGE
7/13/2015	11:00:00 AM	0.31
7/13/2015	11:15:00 AM	0.31
7/13/2015	11:30:00 AM	0.31
7/13/2015	11:45:00 AM	0.31
7/13/2015	12:00:00 PM	0.31
7/13/2015	12:15:00 PM	0.31
7/13/2015	12:30:00 PM	0.31
7/13/2015	12:45:00 PM	0.31
7/13/2015	1:00:00 PM	0.31
7/13/2015	1:15:00 PM	0.31
7/13/2015	1:30:00 PM	0.31
7/13/2015	1:45:00 PM	0.31
7/13/2015	2:00:00 PM	0.31
7/13/2015	2:15:00 PM	0.31
7/13/2015	2:30:00 PM	0.31
7/13/2015	2:45:00 PM	0.31
7/13/2015	3:00:00 PM	0.31
7/13/2015	3:15:00 PM	0.31
7/13/2015	3:30:00 PM	0.31
7/13/2015	3:45:00 PM	0.31
7/13/2015	4:00:00 PM	0.31
7/13/2015	4:15:00 PM	0.31
7/13/2015	4:30:00 PM	0.31
7/13/2015	4:45:00 PM	0.31
7/13/2015	5:00:00 PM	0.31
7/13/2015	5:15:00 PM	0.31
7/13/2015	5:30:00 PM	0.31
7/13/2015	5:45:00 PM	0.31
7/13/2015	6:00:00 PM	0.3
7/13/2015	6:15:00 PM	0.3
7/13/2015	6:30:00 PM	0.3
7/13/2015	6:45:00 PM	0.3
7/13/2015	7:00:00 PM	0.3
7/13/2015	7:15:00 PM	0.3
7/13/2015	7:30:00 PM	0.3
7/13/2015	7:45:00 PM	0.3
7/13/2015	8:00:00 PM	0.3
7/13/2015	8:15:00 PM	0.3
7/13/2015	8:30:00 PM	0.3
7/13/2015	8:45:00 PM	0.3
7/13/2015	9:00:00 PM	0.3
7/13/2015	9:15:00 PM	0.3
7/13/2015	9:30:00 PM	0.3
7/13/2015	9:45:00 PM	0.3
7/13/2015	10:00:00 PM	0.3
7/13/2015	10:15:00 PM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
7/13/2015	10:30:00 PM	0.3
7/13/2015	10:45:00 PM	0.3
7/13/2015	11:00:00 PM	0.3
7/13/2015	11:15:00 PM	0.3
7/13/2015	11:30:00 PM	0.3
7/13/2015	11:45:00 PM	0.3
7/14/2015	12:00:00 AM	0.3
7/14/2015	12:15:00 AM	0.3
7/14/2015	12:30:00 AM	0.3
7/14/2015	12:45:00 AM	0.3
7/14/2015	1:00:00 AM	0.3
7/14/2015	1:15:00 AM	0.3
7/14/2015	1:30:00 AM	0.3
7/14/2015	1:45:00 AM	0.3
7/14/2015	2:00:00 AM	0.3
7/14/2015	2:15:00 AM	0.3
7/14/2015	2:30:00 AM	0.3
7/14/2015	2:45:00 AM	0.3
7/14/2015	3:00:00 AM	0.3
7/14/2015	3:15:00 AM	0.3
7/14/2015	3:30:00 AM	0.3
7/14/2015	3:45:00 AM	0.3
7/14/2015	4:00:00 AM	0.3
7/14/2015	4:15:00 AM	0.3
7/14/2015	4:30:00 AM	0.3
7/14/2015	4:45:00 AM	0.3
7/14/2015	5:00:00 AM	0.3
7/14/2015	5:15:00 AM	0.3
7/14/2015	5:30:00 AM	0.3
7/14/2015	5:45:00 AM	0.3
7/14/2015	6:00:00 AM	0.3
7/14/2015	6:15:00 AM	0.3
7/14/2015	6:30:00 AM	0.3
7/14/2015	6:45:00 AM	0.3
7/14/2015	7:00:00 AM	0.3
7/14/2015	7:15:00 AM	0.3
7/14/2015	7:30:00 AM	0.3
7/14/2015	7:45:00 AM	0.3
7/14/2015	8:00:00 AM	0.3
7/14/2015	8:15:00 AM	0.3
7/14/2015	8:30:00 AM	0.3
7/14/2015	8:45:00 AM	0.3
7/14/2015	9:00:00 AM	0.3
7/14/2015	9:15:00 AM	0.3
7/14/2015	9:30:00 AM	0.3
7/14/2015	9:45:00 AM	0.3

Billy Lake Return Gage

DATE	TIME	GAGE
7/14/2015	10:00:00 AM	0.3
7/14/2015	10:15:00 AM	0.3
7/14/2015	10:30:00 AM	0.3
7/14/2015	10:45:00 AM	0.3
7/14/2015	11:00:00 AM	0.3
7/14/2015	11:15:00 AM	0.3
7/14/2015	11:30:00 AM	0.3
7/14/2015	11:45:00 AM	0.3
7/14/2015	12:00:00 PM	0.3
7/14/2015	12:15:00 PM	0.3
7/14/2015	12:30:00 PM	0.3
7/14/2015	12:45:00 PM	0.3
7/14/2015	1:00:00 PM	0.3
7/14/2015	1:15:00 PM	0.3
7/14/2015	1:30:00 PM	0.3
7/14/2015	1:45:00 PM	0.3
7/14/2015	2:00:00 PM	0.3
7/14/2015	2:15:00 PM	0.3
7/14/2015	2:30:00 PM	0.3
7/14/2015	2:45:00 PM	0.3
7/14/2015	3:00:00 PM	0.3
7/14/2015	3:15:00 PM	0.3
7/14/2015	3:30:00 PM	0.29
7/14/2015	3:45:00 PM	0.29
7/14/2015	4:00:00 PM	0.29
7/14/2015	4:15:00 PM	0.29
7/14/2015	4:30:00 PM	0.29
7/14/2015	4:45:00 PM	0.29
7/14/2015	5:00:00 PM	0.29
7/14/2015	5:15:00 PM	0.29
7/14/2015	5:30:00 PM	0.28
7/14/2015	5:45:00 PM	0.28
7/14/2015	6:00:00 PM	0.28
7/14/2015	6:15:00 PM	0.28
7/14/2015	6:30:00 PM	0.28
7/14/2015	6:45:00 PM	0.28
7/14/2015	7:00:00 PM	0.28
7/14/2015	7:15:00 PM	0.28
7/14/2015	7:30:00 PM	0.28
7/14/2015	7:45:00 PM	0.28
7/14/2015	8:00:00 PM	0.28
7/14/2015	8:15:00 PM	0.28
7/14/2015	8:30:00 PM	0.28
7/14/2015	8:45:00 PM	0.28
7/14/2015	9:00:00 PM	0.28
7/14/2015	9:15:00 PM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
7/14/2015	9:30:00 PM	0.28
7/14/2015	9:45:00 PM	0.28
7/14/2015	10:00:00 PM	0.28
7/14/2015	10:15:00 PM	0.28
7/14/2015	10:30:00 PM	0.28
7/14/2015	10:45:00 PM	0.28
7/14/2015	11:00:00 PM	0.28
7/14/2015	11:15:00 PM	0.28
7/14/2015	11:30:00 PM	0.28
7/14/2015	11:45:00 PM	0.28
7/15/2015	12:00:00 AM	0.28
7/15/2015	12:15:00 AM	0.28
7/15/2015	12:30:00 AM	0.28
7/15/2015	12:45:00 AM	0.28
7/15/2015	1:00:00 AM	0.28
7/15/2015	1:15:00 AM	0.28
7/15/2015	1:30:00 AM	0.28
7/15/2015	1:45:00 AM	0.28
7/15/2015	2:00:00 AM	0.28
7/15/2015	2:15:00 AM	0.28
7/15/2015	2:30:00 AM	0.28
7/15/2015	2:45:00 AM	0.28
7/15/2015	3:00:00 AM	0.28
7/15/2015	3:15:00 AM	0.28
7/15/2015	3:30:00 AM	0.28
7/15/2015	3:45:00 AM	0.28
7/15/2015	4:00:00 AM	0.28
7/15/2015	4:15:00 AM	0.28
7/15/2015	4:30:00 AM	0.28
7/15/2015	4:45:00 AM	0.28
7/15/2015	5:00:00 AM	0.28
7/15/2015	5:15:00 AM	0.28
7/15/2015	5:30:00 AM	0.28
7/15/2015	5:45:00 AM	0.28
7/15/2015	6:00:00 AM	0.28
7/15/2015	6:15:00 AM	0.28
7/15/2015	6:30:00 AM	0.28
7/15/2015	6:45:00 AM	0.28
7/15/2015	7:00:00 AM	0.28
7/15/2015	7:15:00 AM	0.28
7/15/2015	7:30:00 AM	0.28
7/15/2015	7:45:00 AM	0.28
7/15/2015	8:00:00 AM	0.28
7/15/2015	8:15:00 AM	0.28
7/15/2015	8:30:00 AM	0.28
7/15/2015	8:45:00 AM	0.28

Billy Lake Return Gage

DATE	TIME	GAGE
7/15/2015	9:00:00 AM	0.28
7/15/2015	9:15:00 AM	0.28
7/15/2015	9:30:00 AM	0.28
7/15/2015	9:45:00 AM	0.28
7/15/2015	10:00:00 AM	0.28
7/15/2015	10:15:00 AM	0.28
7/15/2015	10:30:00 AM	0.28
7/15/2015	10:45:00 AM	0.28
7/15/2015	11:00:00 AM	0.28
7/15/2015	11:15:00 AM	0.27
7/15/2015	11:30:00 AM	0.27
7/15/2015	11:45:00 AM	0.27
7/15/2015	12:00:00 PM	0.27
7/15/2015	12:15:00 PM	0.27
7/15/2015	12:30:00 PM	0.27
7/15/2015	12:45:00 PM	0.27
7/15/2015	1:00:00 PM	0.27
7/15/2015	1:15:00 PM	0.27
7/15/2015	1:30:00 PM	0.27
7/15/2015	1:45:00 PM	0.27
7/15/2015	2:00:00 PM	0.27
7/15/2015	2:15:00 PM	0.27
7/15/2015	2:30:00 PM	0.27
7/15/2015	2:45:00 PM	0.27
7/15/2015	3:00:00 PM	0.27
7/15/2015	3:15:00 PM	0.26
7/15/2015	3:30:00 PM	0.26
7/15/2015	3:45:00 PM	0.26
7/15/2015	4:00:00 PM	0.26
7/15/2015	4:15:00 PM	0.26
7/15/2015	4:30:00 PM	0.26
7/15/2015	4:45:00 PM	0.26
7/15/2015	5:00:00 PM	0.26
7/15/2015	5:15:00 PM	0.26
7/15/2015	5:30:00 PM	0.26
7/15/2015	5:45:00 PM	0.26
7/15/2015	6:00:00 PM	0.26
7/15/2015	6:15:00 PM	0.26
7/15/2015	6:30:00 PM	0.26
7/15/2015	6:45:00 PM	0.26
7/15/2015	7:00:00 PM	0.26
7/15/2015	7:15:00 PM	0.26
7/15/2015	7:30:00 PM	0.26
7/15/2015	7:45:00 PM	0.26
7/15/2015	8:00:00 PM	0.26
7/15/2015	8:15:00 PM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
7/15/2015	8:30:00 PM	0.26
7/15/2015	8:45:00 PM	0.26
7/15/2015	9:00:00 PM	0.26
7/15/2015	9:15:00 PM	0.26
7/15/2015	9:30:00 PM	0.26
7/15/2015	9:45:00 PM	0.26
7/15/2015	10:00:00 PM	0.26
7/15/2015	10:15:00 PM	0.26
7/15/2015	10:30:00 PM	0.26
7/15/2015	10:45:00 PM	0.26
7/15/2015	11:00:00 PM	0.26
7/15/2015	11:15:00 PM	0.26
7/15/2015	11:30:00 PM	0.26
7/15/2015	11:45:00 PM	0.26
7/16/2015	12:00:00 AM	0.26
7/16/2015	12:15:00 AM	0.26
7/16/2015	12:30:00 AM	0.26
7/16/2015	12:45:00 AM	0.26
7/16/2015	1:00:00 AM	0.26
7/16/2015	1:15:00 AM	0.26
7/16/2015	1:30:00 AM	0.26
7/16/2015	1:45:00 AM	0.26
7/16/2015	2:00:00 AM	0.26
7/16/2015	2:15:00 AM	0.26
7/16/2015	2:30:00 AM	0.26
7/16/2015	2:45:00 AM	0.26
7/16/2015	3:00:00 AM	0.26
7/16/2015	3:15:00 AM	0.26
7/16/2015	3:30:00 AM	0.26
7/16/2015	3:45:00 AM	0.26
7/16/2015	4:00:00 AM	0.26
7/16/2015	4:15:00 AM	0.26
7/16/2015	4:30:00 AM	0.26
7/16/2015	4:45:00 AM	0.26
7/16/2015	5:00:00 AM	0.26
7/16/2015	5:15:00 AM	0.26
7/16/2015	5:30:00 AM	0.26
7/16/2015	5:45:00 AM	0.26
7/16/2015	6:00:00 AM	0.26
7/16/2015	6:15:00 AM	0.26
7/16/2015	6:30:00 AM	0.26
7/16/2015	6:45:00 AM	0.26
7/16/2015	7:00:00 AM	0.26
7/16/2015	7:15:00 AM	0.26
7/16/2015	7:30:00 AM	0.26
7/16/2015	7:45:00 AM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
7/16/2015	8:00:00 AM	0.26
7/16/2015	8:15:00 AM	0.26
7/16/2015	8:30:00 AM	0.26
7/16/2015	8:45:00 AM	0.26
7/16/2015	9:00:00 AM	0.26
7/16/2015	9:15:00 AM	0.26
7/16/2015	9:30:00 AM	0.25
7/16/2015	9:45:00 AM	0.25
7/16/2015	10:00:00 AM	0.25
7/16/2015	10:15:00 AM	0.25
7/16/2015	10:30:00 AM	0.25
7/16/2015	10:45:00 AM	0.25
7/16/2015	11:00:00 AM	0.25
7/16/2015	11:15:00 AM	0.25
7/16/2015	11:30:00 AM	0.25
7/16/2015	11:45:00 AM	0.25
7/16/2015	12:00:00 PM	0.25
7/16/2015	12:15:00 PM	0.25
7/16/2015	12:30:00 PM	0.25
7/16/2015	12:45:00 PM	0.25
7/16/2015	1:00:00 PM	0.25
7/16/2015	1:15:00 PM	0.25
7/16/2015	1:30:00 PM	0.25
7/16/2015	1:45:00 PM	0.25
7/16/2015	2:00:00 PM	0.25
7/16/2015	2:15:00 PM	0.25
7/16/2015	2:30:00 PM	0.25
7/16/2015	2:45:00 PM	0.25
7/16/2015	3:00:00 PM	0.25
7/16/2015	3:15:00 PM	0.25
7/16/2015	3:30:00 PM	0.25
7/16/2015	3:45:00 PM	0.25
7/16/2015	4:00:00 PM	0.25
7/16/2015	4:15:00 PM	0.25
7/16/2015	4:30:00 PM	0.25
7/16/2015	4:45:00 PM	0.25
7/16/2015	5:00:00 PM	0.25
7/16/2015	5:15:00 PM	0.25
7/16/2015	5:30:00 PM	0.25
7/16/2015	5:45:00 PM	0.25
7/16/2015	6:00:00 PM	0.25
7/16/2015	6:15:00 PM	0.25
7/16/2015	6:30:00 PM	0.25
7/16/2015	6:45:00 PM	0.25
7/16/2015	7:00:00 PM	0.25
7/16/2015	7:15:00 PM	0.24

Billy Lake Return Gage

DATE	TIME	GAGE
7/16/2015	7:30:00 PM	0.24
7/16/2015	7:45:00 PM	0.24
7/16/2015	8:00:00 PM	0.24
7/16/2015	8:15:00 PM	0.24
7/16/2015	8:30:00 PM	0.24
7/16/2015	8:45:00 PM	0.24
7/16/2015	9:00:00 PM	0.24
7/16/2015	9:15:00 PM	0.24
7/16/2015	9:30:00 PM	0.24
7/16/2015	9:45:00 PM	0.24
7/16/2015	10:00:00 PM	0.24
7/16/2015	10:15:00 PM	0.24
7/16/2015	10:30:00 PM	0.24
7/16/2015	10:45:00 PM	0.24
7/16/2015	11:00:00 PM	0.24
7/16/2015	11:15:00 PM	0.24
7/16/2015	11:30:00 PM	0.24
7/16/2015	11:45:00 PM	0.24
7/17/2015	12:00:00 AM	0.24
7/17/2015	12:15:00 AM	0.24
7/17/2015	12:30:00 AM	0.24
7/17/2015	12:45:00 AM	0.24
7/17/2015	1:00:00 AM	0.24
7/17/2015	1:15:00 AM	0.24
7/17/2015	1:30:00 AM	0.24
7/17/2015	1:45:00 AM	0.24
7/17/2015	2:00:00 AM	0.24
7/17/2015	2:15:00 AM	0.24
7/17/2015	2:30:00 AM	0.24
7/17/2015	2:45:00 AM	0.24
7/17/2015	3:00:00 AM	0.24
7/17/2015	3:15:00 AM	0.24
7/17/2015	3:30:00 AM	0.24
7/17/2015	3:45:00 AM	0.24
7/17/2015	4:00:00 AM	0.24
7/17/2015	4:15:00 AM	0.24
7/17/2015	4:30:00 AM	0.24
7/17/2015	4:45:00 AM	0.24
7/17/2015	5:00:00 AM	0.24
7/17/2015	5:15:00 AM	0.24
7/17/2015	5:30:00 AM	0.24
7/17/2015	5:45:00 AM	0.24
7/17/2015	6:00:00 AM	0.24
7/17/2015	6:15:00 AM	0.24
7/17/2015	6:30:00 AM	0.24
7/17/2015	6:45:00 AM	0.24

Billy Lake Return Gage

DATE	TIME	GAGE
7/17/2015	7:00:00 AM	0.24
7/17/2015	7:15:00 AM	0.24
7/17/2015	7:30:00 AM	0.24
7/17/2015	7:45:00 AM	0.24
7/17/2015	8:00:00 AM	0.24
7/17/2015	8:15:00 AM	0.24
7/17/2015	8:30:00 AM	0.24
7/17/2015	8:45:00 AM	0.24
7/17/2015	9:00:00 AM	0.24
7/17/2015	9:15:00 AM	0.24
7/17/2015	9:30:00 AM	0.24
7/17/2015	9:45:00 AM	0.24
7/17/2015	10:00:00 AM	0.24
7/17/2015	10:15:00 AM	0.24
7/17/2015	10:30:00 AM	0.24
7/17/2015	10:45:00 AM	0.24
7/17/2015	11:00:00 AM	0.24
7/17/2015	11:15:00 AM	0.24
7/17/2015	11:30:00 AM	0.24
7/17/2015	11:45:00 AM	0.24
7/17/2015	12:00:00 PM	0.24
7/17/2015	12:15:00 PM	0.24
7/17/2015	12:30:00 PM	0.24
7/17/2015	12:45:00 PM	0.24
7/17/2015	1:00:00 PM	0.24
7/17/2015	1:15:00 PM	0.24
7/17/2015	1:30:00 PM	0.23
7/17/2015	1:45:00 PM	0.23
7/17/2015	2:00:00 PM	0.23
7/17/2015	2:15:00 PM	0.23
7/17/2015	2:30:00 PM	0.23
7/17/2015	2:45:00 PM	0.23
7/17/2015	3:00:00 PM	0.23
7/17/2015	3:15:00 PM	0.23
7/17/2015	3:30:00 PM	0.23
7/17/2015	3:45:00 PM	0.23
7/17/2015	4:00:00 PM	0.23
7/17/2015	4:15:00 PM	0.23
7/17/2015	4:30:00 PM	0.22
7/17/2015	4:45:00 PM	0.22
7/17/2015	5:00:00 PM	0.22
7/17/2015	5:15:00 PM	0.22
7/17/2015	5:30:00 PM	0.22
7/17/2015	5:45:00 PM	0.22
7/17/2015	6:00:00 PM	0.22
7/17/2015	6:15:00 PM	0.22

Billy Lake Return Gage

DATE	TIME	GAGE
7/17/2015	6:30:00 PM	0.22
7/17/2015	6:45:00 PM	0.22
7/17/2015	7:00:00 PM	0.22
7/17/2015	7:15:00 PM	0.22
7/17/2015	7:30:00 PM	0.22
7/17/2015	7:45:00 PM	0.22
7/17/2015	8:00:00 PM	0.22
7/17/2015	8:15:00 PM	0.22
7/17/2015	8:30:00 PM	0.22
7/17/2015	8:45:00 PM	0.22
7/17/2015	9:00:00 PM	0.22
7/17/2015	9:15:00 PM	0.22
7/17/2015	9:30:00 PM	0.22
7/17/2015	9:45:00 PM	0.22
7/17/2015	10:00:00 PM	0.22
7/17/2015	10:15:00 PM	0.22
7/17/2015	10:30:00 PM	0.22
7/17/2015	10:45:00 PM	0.22
7/17/2015	11:00:00 PM	0.22
7/17/2015	11:15:00 PM	0.22
7/17/2015	11:30:00 PM	0.22
7/17/2015	11:45:00 PM	0.22
7/18/2015	12:00:00 AM	0.22
7/18/2015	12:15:00 AM	0.22
7/18/2015	12:30:00 AM	0.22
7/18/2015	12:45:00 AM	0.22
7/18/2015	1:00:00 AM	0.22
7/18/2015	1:15:00 AM	0.22
7/18/2015	1:30:00 AM	0.22
7/18/2015	1:45:00 AM	0.22
7/18/2015	2:00:00 AM	0.22
7/18/2015	2:15:00 AM	0.22
7/18/2015	2:30:00 AM	0.22
7/18/2015	2:45:00 AM	0.22
7/18/2015	3:00:00 AM	0.22
7/18/2015	3:15:00 AM	0.22
7/18/2015	3:30:00 AM	0.22
7/18/2015	3:45:00 AM	0.22
7/18/2015	4:00:00 AM	0.22
7/18/2015	4:15:00 AM	0.22
7/18/2015	4:30:00 AM	0.22
7/18/2015	4:45:00 AM	0.22
7/18/2015	5:00:00 AM	0.22
7/18/2015	5:15:00 AM	0.22
7/18/2015	5:30:00 AM	0.22
7/18/2015	5:45:00 AM	0.22

Billy Lake Return Gage

DATE	TIME	GAGE
7/18/2015	6:00:00 AM	0.22
7/18/2015	6:15:00 AM	0.22
7/18/2015	6:30:00 AM	0.22
7/18/2015	6:45:00 AM	0.22
7/18/2015	7:00:00 AM	0.22
7/18/2015	7:15:00 AM	0.22
7/18/2015	7:30:00 AM	0.22
7/18/2015	7:45:00 AM	0.22
7/18/2015	8:00:00 AM	0.22
7/18/2015	8:15:00 AM	0.22
7/18/2015	8:30:00 AM	0.22
7/18/2015	8:45:00 AM	0.22
7/18/2015	9:00:00 AM	0.22
7/18/2015	9:15:00 AM	0.22
7/18/2015	9:30:00 AM	0.22
7/18/2015	9:45:00 AM	0.22
7/18/2015	10:00:00 AM	0.22
7/18/2015	10:15:00 AM	0.22
7/18/2015	10:30:00 AM	0.22
7/18/2015	10:45:00 AM	0.22
7/18/2015	11:00:00 AM	0.22
7/18/2015	11:15:00 AM	0.22
7/18/2015	11:30:00 AM	0.22
7/18/2015	11:45:00 AM	0.22
7/18/2015	12:00:00 PM	0.22
7/18/2015	12:15:00 PM	0.22
7/18/2015	12:30:00 PM	0.22
7/18/2015	12:45:00 PM	0.22
7/18/2015	1:00:00 PM	0.22
7/18/2015	1:15:00 PM	0.22
7/18/2015	1:30:00 PM	0.21
7/18/2015	1:45:00 PM	0.21
7/18/2015	2:00:00 PM	0.21
7/18/2015	2:15:00 PM	0.21
7/18/2015	2:30:00 PM	0.21
7/18/2015	2:45:00 PM	0.21
7/18/2015	3:00:00 PM	0.21
7/18/2015	3:15:00 PM	0.21
7/18/2015	3:30:00 PM	0.21
7/18/2015	3:45:00 PM	0.21
7/18/2015	4:00:00 PM	0.21
7/18/2015	4:15:00 PM	0.21
7/18/2015	4:30:00 PM	0.21
7/18/2015	4:45:00 PM	0.21
7/18/2015	5:00:00 PM	0.2
7/18/2015	5:15:00 PM	0.2

Billy Lake Return Gage

DATE	TIME	GAGE
7/18/2015	5:30:00 PM	0.2
7/18/2015	5:45:00 PM	0.2
7/18/2015	6:00:00 PM	0.2
7/18/2015	6:15:00 PM	0.2
7/18/2015	6:30:00 PM	0.2
7/18/2015	6:45:00 PM	0.2
7/18/2015	7:00:00 PM	0.2
7/18/2015	7:15:00 PM	0.2
7/18/2015	7:30:00 PM	0.2
7/18/2015	7:45:00 PM	0.2
7/18/2015	8:00:00 PM	0.2
7/18/2015	8:15:00 PM	0.2
7/18/2015	8:30:00 PM	0.2
7/18/2015	8:45:00 PM	0.2
7/18/2015	9:00:00 PM	0.2
7/18/2015	9:15:00 PM	0.2
7/18/2015	9:30:00 PM	0.2
7/18/2015	9:45:00 PM	0.2
7/18/2015	10:00:00 PM	0.2
7/18/2015	10:15:00 PM	0.2
7/18/2015	10:30:00 PM	0.2
7/18/2015	10:45:00 PM	0.2
7/18/2015	11:00:00 PM	0.2
7/18/2015	11:15:00 PM	0.2
7/18/2015	11:30:00 PM	0.2
7/18/2015	11:45:00 PM	0.2
7/19/2015	12:00:00 AM	0.2
7/19/2015	12:15:00 AM	0.2
7/19/2015	12:30:00 AM	0.2
7/19/2015	12:45:00 AM	0.2
7/19/2015	1:00:00 AM	0.2
7/19/2015	1:15:00 AM	0.2
7/19/2015	1:30:00 AM	0.2
7/19/2015	1:45:00 AM	0.2
7/19/2015	2:00:00 AM	0.2
7/19/2015	2:15:00 AM	0.2
7/19/2015	2:30:00 AM	0.2
7/19/2015	2:45:00 AM	0.2
7/19/2015	3:00:00 AM	0.2
7/19/2015	3:15:00 AM	0.2
7/19/2015	3:30:00 AM	0.2
7/19/2015	3:45:00 AM	0.2
7/19/2015	4:00:00 AM	0.2
7/19/2015	4:15:00 AM	0.2
7/19/2015	4:30:00 AM	0.2
7/19/2015	4:45:00 AM	0.2

Billy Lake Return Gage

DATE	TIME	GAGE
7/19/2015	5:00:00 AM	0.2
7/19/2015	5:15:00 AM	0.2
7/19/2015	5:30:00 AM	0.2
7/19/2015	5:45:00 AM	0.2
7/19/2015	6:00:00 AM	0.2
7/19/2015	6:15:00 AM	0.2
7/19/2015	6:30:00 AM	0.2
7/19/2015	6:45:00 AM	0.2
7/19/2015	7:00:00 AM	0.2
7/19/2015	7:15:00 AM	0.2
7/19/2015	7:30:00 AM	0.2
7/19/2015	7:45:00 AM	0.2
7/19/2015	8:00:00 AM	0.2
7/19/2015	8:15:00 AM	0.2
7/19/2015	8:30:00 AM	0.2
7/19/2015	8:45:00 AM	0.2
7/19/2015	9:00:00 AM	0.2
7/19/2015	9:15:00 AM	0.2
7/19/2015	9:30:00 AM	0.2
7/19/2015	9:45:00 AM	0.2
7/19/2015	10:00:00 AM	0.2
7/19/2015	10:15:00 AM	0.2
7/19/2015	10:30:00 AM	0.2
7/19/2015	10:45:00 AM	0.2
7/19/2015	11:00:00 AM	0.2
7/19/2015	11:15:00 AM	0.2
7/19/2015	11:30:00 AM	0.2
7/19/2015	11:45:00 AM	0.2
7/19/2015	12:00:00 PM	0.2
7/19/2015	12:15:00 PM	0.2
7/19/2015	12:30:00 PM	0.2
7/19/2015	12:45:00 PM	0.2
7/19/2015	1:00:00 PM	0.2
7/19/2015	1:15:00 PM	0.2
7/19/2015	1:30:00 PM	0.2
7/19/2015	1:45:00 PM	0.2
7/19/2015	2:00:00 PM	0.2
7/19/2015	2:15:00 PM	0.2
7/19/2015	2:30:00 PM	0.2
7/19/2015	2:45:00 PM	0.2
7/19/2015	3:00:00 PM	0.2
7/19/2015	3:15:00 PM	0.2
7/19/2015	3:30:00 PM	0.2
7/19/2015	3:45:00 PM	0.2
7/19/2015	4:00:00 PM	0.19
7/19/2015	4:15:00 PM	0.19

Billy Lake Return Gage

DATE	TIME	GAGE
7/19/2015	4:30:00 PM	0.19
7/19/2015	4:45:00 PM	0.19
7/19/2015	5:00:00 PM	0.19
7/19/2015	5:15:00 PM	0.19
7/19/2015	5:30:00 PM	0.19
7/19/2015	5:45:00 PM	0.19
7/19/2015	6:00:00 PM	0.19
7/19/2015	6:15:00 PM	0.19
7/19/2015	6:30:00 PM	0.19
7/19/2015	6:45:00 PM	0.19
7/19/2015	7:00:00 PM	0.19
7/19/2015	7:15:00 PM	0.19
7/19/2015	7:30:00 PM	0.19
7/19/2015	7:45:00 PM	0.19
7/19/2015	8:00:00 PM	0.19
7/19/2015	8:15:00 PM	0.19
7/19/2015	8:30:00 PM	0.19
7/19/2015	8:45:00 PM	0.19
7/19/2015	9:00:00 PM	0.19
7/19/2015	9:15:00 PM	0.19
7/19/2015	9:30:00 PM	0.19
7/19/2015	9:45:00 PM	0.19
7/19/2015	10:00:00 PM	0.19
7/19/2015	10:15:00 PM	0.19
7/19/2015	10:30:00 PM	0.19
7/19/2015	10:45:00 PM	0.19
7/19/2015	11:00:00 PM	0.19
7/19/2015	11:15:00 PM	0.19
7/19/2015	11:30:00 PM	0.19
7/19/2015	11:45:00 PM	0.19
7/20/2015	12:00:00 AM	0.19
7/20/2015	12:15:00 AM	0.19
7/20/2015	12:30:00 AM	0.19
7/20/2015	12:45:00 AM	0.19
7/20/2015	1:00:00 AM	0.19
7/20/2015	1:15:00 AM	0.19
7/20/2015	1:30:00 AM	0.19
7/20/2015	1:45:00 AM	0.19
7/20/2015	2:00:00 AM	0.19
7/20/2015	2:15:00 AM	0.19
7/20/2015	2:30:00 AM	0.19
7/20/2015	2:45:00 AM	0.19
7/20/2015	3:00:00 AM	0.19
7/20/2015	3:15:00 AM	0.19
7/20/2015	3:30:00 AM	0.19
7/20/2015	3:45:00 AM	0.19

Billy Lake Return Gage

DATE	TIME	GAGE
7/20/2015	4:00:00 AM	0.19
7/20/2015	4:15:00 AM	0.19
7/20/2015	4:30:00 AM	0.19
7/20/2015	4:45:00 AM	0.19
7/20/2015	5:00:00 AM	0.19
7/20/2015	5:15:00 AM	0.19
7/20/2015	5:30:00 AM	0.19
7/20/2015	5:45:00 AM	0.2
7/20/2015	6:00:00 AM	0.2
7/20/2015	6:15:00 AM	0.2
7/20/2015	6:30:00 AM	0.2
7/20/2015	6:45:00 AM	0.2
7/20/2015	7:00:00 AM	0.2
7/20/2015	7:15:00 AM	0.2
7/20/2015	7:30:00 AM	0.2
7/20/2015	7:45:00 AM	0.2
7/20/2015	8:00:00 AM	0.2
7/20/2015	8:15:00 AM	0.2
7/20/2015	8:30:00 AM	0.2
7/20/2015	8:45:00 AM	0.2
7/20/2015	9:00:00 AM	0.2
7/20/2015	9:15:00 AM	0.2
7/20/2015	9:30:00 AM	0.2
7/20/2015	9:45:00 AM	0.2
7/20/2015	10:00:00 AM	0.2
7/20/2015	10:15:00 AM	0.2
7/20/2015	10:30:00 AM	0.2
7/20/2015	10:45:00 AM	0.2
7/20/2015	11:00:00 AM	0.2
7/20/2015	11:15:00 AM	0.2
7/20/2015	11:30:00 AM	0.2
7/20/2015	11:45:00 AM	0.21
7/20/2015	12:00:00 PM	0.21
7/20/2015	12:15:00 PM	0.21
7/20/2015	12:30:00 PM	0.21
7/20/2015	12:45:00 PM	0.21
7/20/2015	1:00:00 PM	0.21
7/20/2015	1:15:00 PM	0.21
7/20/2015	1:30:00 PM	0.21
7/20/2015	1:45:00 PM	0.21
7/20/2015	2:00:00 PM	0.21
7/20/2015	2:15:00 PM	0.21
7/20/2015	2:30:00 PM	0.21
7/20/2015	2:45:00 PM	0.21
7/20/2015	3:00:00 PM	0.21
7/20/2015	3:15:00 PM	0.21

Billy Lake Return Gage

DATE	TIME	GAGE
7/20/2015	3:30:00 PM	0.21
7/20/2015	3:45:00 PM	0.21
7/20/2015	4:00:00 PM	0.21
7/20/2015	4:15:00 PM	0.21
7/20/2015	4:30:00 PM	0.21
7/20/2015	4:45:00 PM	0.21
7/20/2015	5:00:00 PM	0.21
7/20/2015	5:15:00 PM	0.21
7/20/2015	5:30:00 PM	0.21
7/20/2015	5:45:00 PM	0.21
7/20/2015	6:00:00 PM	0.21
7/20/2015	6:15:00 PM	0.22
7/20/2015	6:30:00 PM	0.22
7/20/2015	6:45:00 PM	0.22
7/20/2015	7:00:00 PM	0.22
7/20/2015	7:15:00 PM	0.22
7/20/2015	7:30:00 PM	0.22
7/20/2015	7:45:00 PM	0.22
7/20/2015	8:00:00 PM	0.22
7/20/2015	8:15:00 PM	0.22
7/20/2015	8:30:00 PM	0.22
7/20/2015	8:45:00 PM	0.22
7/20/2015	9:00:00 PM	0.22
7/20/2015	9:15:00 PM	0.22
7/20/2015	9:30:00 PM	0.22
7/20/2015	9:45:00 PM	0.22
7/20/2015	10:00:00 PM	0.22
7/20/2015	10:15:00 PM	0.22
7/20/2015	10:30:00 PM	0.22
7/20/2015	10:45:00 PM	0.22
7/20/2015	11:00:00 PM	0.22
7/20/2015	11:15:00 PM	0.22
7/20/2015	11:30:00 PM	0.22
7/20/2015	11:45:00 PM	0.23
7/21/2015	12:00:00 AM	0.23
7/21/2015	12:15:00 AM	0.23
7/21/2015	12:30:00 AM	0.23
7/21/2015	12:45:00 AM	0.23
7/21/2015	1:00:00 AM	0.23
7/21/2015	1:15:00 AM	0.23
7/21/2015	1:30:00 AM	0.23
7/21/2015	1:45:00 AM	0.23
7/21/2015	2:00:00 AM	0.23
7/21/2015	2:15:00 AM	0.23
7/21/2015	2:30:00 AM	0.23
7/21/2015	2:45:00 AM	0.23

Billy Lake Return Gage

DATE	TIME	GAGE
7/21/2015	3:00:00 AM	0.23
7/21/2015	3:15:00 AM	0.23
7/21/2015	3:30:00 AM	0.23
7/21/2015	3:45:00 AM	0.23
7/21/2015	4:00:00 AM	0.23
7/21/2015	4:15:00 AM	0.23
7/21/2015	4:30:00 AM	0.23
7/21/2015	4:45:00 AM	0.23
7/21/2015	5:00:00 AM	0.23
7/21/2015	5:15:00 AM	0.23
7/21/2015	5:30:00 AM	0.23
7/21/2015	5:45:00 AM	0.23
7/21/2015	6:00:00 AM	0.23
7/21/2015	6:15:00 AM	0.23
7/21/2015	6:30:00 AM	0.24
7/21/2015	6:45:00 AM	0.24
7/21/2015	7:00:00 AM	0.24
7/21/2015	7:15:00 AM	0.24
7/21/2015	7:30:00 AM	0.24
7/21/2015	7:45:00 AM	0.24
7/21/2015	8:00:00 AM	0.24
7/21/2015	8:15:00 AM	0.24
7/21/2015	8:30:00 AM	0.24
7/21/2015	8:45:00 AM	0.24
7/21/2015	9:00:00 AM	0.24
7/21/2015	9:15:00 AM	0.24
7/21/2015	9:30:00 AM	0.24
7/21/2015	9:45:00 AM	0.24
7/21/2015	10:00:00 AM	0.24
7/21/2015	10:15:00 AM	0.24
7/21/2015	10:30:00 AM	0.24
7/21/2015	10:45:00 AM	0.24
7/21/2015	11:00:00 AM	0.24
7/21/2015	11:15:00 AM	0.24
7/21/2015	11:30:00 AM	0.24
7/21/2015	11:45:00 AM	0.24
7/21/2015	12:00:00 PM	0.24
7/21/2015	12:15:00 PM	0.24
7/21/2015	12:30:00 PM	0.24
7/21/2015	12:45:00 PM	0.24
7/21/2015	1:00:00 PM	0.24
7/21/2015	1:15:00 PM	0.24
7/21/2015	1:30:00 PM	0.24
7/21/2015	1:45:00 PM	0.24
7/21/2015	2:00:00 PM	0.24
7/21/2015	2:15:00 PM	0.24

Billy Lake Return Gage

DATE	TIME	GAGE
7/21/2015	2:30:00 PM	0.24
7/21/2015	2:45:00 PM	0.24
7/21/2015	3:00:00 PM	0.24
7/21/2015	3:15:00 PM	0.24
7/21/2015	3:30:00 PM	0.24
7/21/2015	3:45:00 PM	0.24
7/21/2015	4:00:00 PM	0.24
7/21/2015	4:15:00 PM	0.24
7/21/2015	4:30:00 PM	0.24
7/21/2015	4:45:00 PM	0.24
7/21/2015	5:00:00 PM	0.24
7/21/2015	5:15:00 PM	0.24
7/21/2015	5:30:00 PM	0.24
7/21/2015	5:45:00 PM	0.24
7/21/2015	6:00:00 PM	0.24
7/21/2015	6:15:00 PM	0.24
7/21/2015	6:30:00 PM	0.24
7/21/2015	6:45:00 PM	0.24
7/21/2015	7:00:00 PM	0.24
7/21/2015	7:15:00 PM	0.24
7/21/2015	7:30:00 PM	0.24
7/21/2015	7:45:00 PM	0.24
7/21/2015	8:00:00 PM	0.25
7/21/2015	8:15:00 PM	0.25
7/21/2015	8:30:00 PM	0.25
7/21/2015	8:45:00 PM	0.25
7/21/2015	9:00:00 PM	0.25
7/21/2015	9:15:00 PM	0.25
7/21/2015	9:30:00 PM	0.25
7/21/2015	9:45:00 PM	0.25
7/21/2015	10:00:00 PM	0.25
7/21/2015	10:15:00 PM	0.25
7/21/2015	10:30:00 PM	0.25
7/21/2015	10:45:00 PM	0.25
7/21/2015	11:00:00 PM	0.25
7/21/2015	11:15:00 PM	0.25
7/21/2015	11:30:00 PM	0.25
7/21/2015	11:45:00 PM	0.25
7/22/2015	12:00:00 AM	0.25
7/22/2015	12:15:00 AM	0.25
7/22/2015	12:30:00 AM	0.25
7/22/2015	12:45:00 AM	0.25
7/22/2015	1:00:00 AM	0.25
7/22/2015	1:15:00 AM	0.25
7/22/2015	1:30:00 AM	0.25
7/22/2015	1:45:00 AM	0.25

Billy Lake Return Gage

DATE	TIME	GAGE
7/22/2015	2:00:00 AM	0.25
7/22/2015	2:15:00 AM	0.25
7/22/2015	2:30:00 AM	0.25
7/22/2015	2:45:00 AM	0.25
7/22/2015	3:00:00 AM	0.25
7/22/2015	3:15:00 AM	0.25
7/22/2015	3:30:00 AM	0.25
7/22/2015	3:45:00 AM	0.25
7/22/2015	4:00:00 AM	0.25
7/22/2015	4:15:00 AM	0.25
7/22/2015	4:30:00 AM	0.25
7/22/2015	4:45:00 AM	0.25
7/22/2015	5:00:00 AM	0.25
7/22/2015	5:15:00 AM	0.25
7/22/2015	5:30:00 AM	0.25
7/22/2015	5:45:00 AM	0.25
7/22/2015	6:00:00 AM	0.25
7/22/2015	6:15:00 AM	0.25
7/22/2015	6:30:00 AM	0.25
7/22/2015	6:45:00 AM	0.25
7/22/2015	7:00:00 AM	0.25
7/22/2015	7:15:00 AM	0.25
7/22/2015	7:30:00 AM	0.25
7/22/2015	7:45:00 AM	0.25
7/22/2015	8:00:00 AM	0.25
7/22/2015	8:15:00 AM	0.25
7/22/2015	8:30:00 AM	0.25
7/22/2015	8:45:00 AM	0.25
7/22/2015	9:00:00 AM	0.25
7/22/2015	9:15:00 AM	0.25
7/22/2015	9:30:00 AM	0.25
7/22/2015	9:45:00 AM	0.25
7/22/2015	10:00:00 AM	0.25
7/22/2015	10:15:00 AM	0.25
7/22/2015	10:30:00 AM	0.25
7/22/2015	10:45:00 AM	0.25
7/22/2015	11:00:00 AM	0.25
7/22/2015	11:15:00 AM	0.25
7/22/2015	11:30:00 AM	0.25
7/22/2015	11:45:00 AM	0.25
7/22/2015	12:00:00 PM	0.25
7/22/2015	12:15:00 PM	0.25
7/22/2015	12:30:00 PM	0.25
7/22/2015	12:45:00 PM	0.25
7/22/2015	1:00:00 PM	0.25
7/22/2015	1:15:00 PM	0.25

Billy Lake Return Gage

DATE	TIME	GAGE
7/22/2015	1:30:00 PM	0.25
7/22/2015	1:45:00 PM	0.25
7/22/2015	2:00:00 PM	0.25
7/22/2015	2:15:00 PM	0.25
7/22/2015	2:30:00 PM	0.25
7/22/2015	2:45:00 PM	0.25
7/22/2015	3:00:00 PM	0.25
7/22/2015	3:15:00 PM	0.25
7/22/2015	3:30:00 PM	0.25
7/22/2015	3:45:00 PM	0.25
7/22/2015	4:00:00 PM	0.25
7/22/2015	4:15:00 PM	0.25
7/22/2015	4:30:00 PM	0.25
7/22/2015	4:45:00 PM	0.25
7/22/2015	5:00:00 PM	0.25
7/22/2015	5:15:00 PM	0.25
7/22/2015	5:30:00 PM	0.25
7/22/2015	5:45:00 PM	0.25
7/22/2015	6:00:00 PM	0.25
7/22/2015	6:15:00 PM	0.25
7/22/2015	6:30:00 PM	0.25
7/22/2015	6:45:00 PM	0.25
7/22/2015	7:00:00 PM	0.25
7/22/2015	7:15:00 PM	0.25
7/22/2015	7:30:00 PM	0.25
7/22/2015	7:45:00 PM	0.25
7/22/2015	8:00:00 PM	0.25
7/22/2015	8:15:00 PM	0.25
7/22/2015	8:30:00 PM	0.25
7/22/2015	8:45:00 PM	0.25
7/22/2015	9:00:00 PM	0.25
7/22/2015	9:15:00 PM	0.25
7/22/2015	9:30:00 PM	0.25
7/22/2015	9:45:00 PM	0.25
7/22/2015	10:00:00 PM	0.25
7/22/2015	10:15:00 PM	0.25
7/22/2015	10:30:00 PM	0.25
7/22/2015	10:45:00 PM	0.25
7/22/2015	11:00:00 PM	0.25
7/22/2015	11:15:00 PM	0.25
7/22/2015	11:30:00 PM	0.25
7/22/2015	11:45:00 PM	0.25
7/23/2015	12:00:00 AM	0.25
7/23/2015	12:15:00 AM	0.25
7/23/2015	12:30:00 AM	0.25
7/23/2015	12:45:00 AM	0.25

Billy Lake Return Gage

DATE	TIME	GAGE
7/23/2015	1:00:00 AM	0.25
7/23/2015	1:15:00 AM	0.25
7/23/2015	1:30:00 AM	0.25
7/23/2015	1:45:00 AM	0.25
7/23/2015	2:00:00 AM	0.25
7/23/2015	2:15:00 AM	0.25
7/23/2015	2:30:00 AM	0.25
7/23/2015	2:45:00 AM	0.25
7/23/2015	3:00:00 AM	0.25
7/23/2015	3:15:00 AM	0.25
7/23/2015	3:30:00 AM	0.25
7/23/2015	3:45:00 AM	0.25
7/23/2015	4:00:00 AM	0.25
7/23/2015	4:15:00 AM	0.25
7/23/2015	4:30:00 AM	0.25
7/23/2015	4:45:00 AM	0.25
7/23/2015	5:00:00 AM	0.25
7/23/2015	5:15:00 AM	0.25
7/23/2015	5:30:00 AM	0.25
7/23/2015	5:45:00 AM	0.25
7/23/2015	6:00:00 AM	0.25
7/23/2015	6:15:00 AM	0.26
7/23/2015	6:30:00 AM	0.26
7/23/2015	6:45:00 AM	0.26
7/23/2015	7:00:00 AM	0.26
7/23/2015	7:15:00 AM	0.26
7/23/2015	7:30:00 AM	0.26
7/23/2015	7:45:00 AM	0.26
7/23/2015	8:00:00 AM	0.26
7/23/2015	8:15:00 AM	0.26
7/23/2015	8:30:00 AM	0.26
7/23/2015	8:45:00 AM	0.26
7/23/2015	9:00:00 AM	0.26
7/23/2015	9:15:00 AM	0.26
7/23/2015	9:30:00 AM	0.26
7/23/2015	9:45:00 AM	0.26
7/23/2015	10:00:00 AM	0.26
7/23/2015	10:15:00 AM	0.26
7/23/2015	10:30:00 AM	0.26
7/23/2015	10:45:00 AM	0.26
7/23/2015	11:00:00 AM	0.26
7/23/2015	11:15:00 AM	0.26
7/23/2015	11:30:00 AM	0.26
7/23/2015	11:45:00 AM	0.26
7/23/2015	12:00:00 PM	0.26
7/23/2015	12:15:00 PM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
7/23/2015	12:30:00 PM	0.26
7/23/2015	12:45:00 PM	0.26
7/23/2015	1:00:00 PM	0.26
7/23/2015	1:15:00 PM	0.26
7/23/2015	1:30:00 PM	0.26
7/23/2015	1:45:00 PM	0.26
7/23/2015	2:00:00 PM	0.26
7/23/2015	2:15:00 PM	0.26
7/23/2015	2:30:00 PM	0.26
7/23/2015	2:45:00 PM	0.26
7/23/2015	3:00:00 PM	0.26
7/23/2015	3:15:00 PM	0.26
7/23/2015	3:30:00 PM	0.26
7/23/2015	3:45:00 PM	0.26
7/23/2015	4:00:00 PM	0.26
7/23/2015	4:15:00 PM	0.26
7/23/2015	4:30:00 PM	0.26
7/23/2015	4:45:00 PM	0.26
7/23/2015	5:00:00 PM	0.26
7/23/2015	5:15:00 PM	0.26
7/23/2015	5:30:00 PM	0.26
7/23/2015	5:45:00 PM	0.26
7/23/2015	6:00:00 PM	0.26
7/23/2015	6:15:00 PM	0.26
7/23/2015	6:30:00 PM	0.26
7/23/2015	6:45:00 PM	0.26
7/23/2015	7:00:00 PM	0.26
7/23/2015	7:15:00 PM	0.26
7/23/2015	7:30:00 PM	0.26
7/23/2015	7:45:00 PM	0.26
7/23/2015	8:00:00 PM	0.26
7/23/2015	8:15:00 PM	0.26
7/23/2015	8:30:00 PM	0.26
7/23/2015	8:45:00 PM	0.26
7/23/2015	9:00:00 PM	0.26
7/23/2015	9:15:00 PM	0.26
7/23/2015	9:30:00 PM	0.26
7/23/2015	9:45:00 PM	0.26
7/23/2015	10:00:00 PM	0.26
7/23/2015	10:15:00 PM	0.26
7/23/2015	10:30:00 PM	0.26
7/23/2015	10:45:00 PM	0.26
7/23/2015	11:00:00 PM	0.26
7/23/2015	11:15:00 PM	0.26
7/23/2015	11:30:00 PM	0.26
7/23/2015	11:45:00 PM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
7/24/2015	12:00:00 AM	0.26
7/24/2015	12:15:00 AM	0.26
7/24/2015	12:30:00 AM	0.27
7/24/2015	12:45:00 AM	0.27
7/24/2015	1:00:00 AM	0.27
7/24/2015	1:15:00 AM	0.27
7/24/2015	1:30:00 AM	0.27
7/24/2015	1:45:00 AM	0.27
7/24/2015	2:00:00 AM	0.27
7/24/2015	2:15:00 AM	0.27
7/24/2015	2:30:00 AM	0.27
7/24/2015	2:45:00 AM	0.27
7/24/2015	3:00:00 AM	0.27
7/24/2015	3:15:00 AM	0.27
7/24/2015	3:30:00 AM	0.27
7/24/2015	3:45:00 AM	0.27
7/24/2015	4:00:00 AM	0.27
7/24/2015	4:15:00 AM	0.27
7/24/2015	4:30:00 AM	0.27
7/24/2015	4:45:00 AM	0.27
7/24/2015	5:00:00 AM	0.27
7/24/2015	5:15:00 AM	0.27
7/24/2015	5:30:00 AM	0.27
7/24/2015	5:45:00 AM	0.27
7/24/2015	6:00:00 AM	0.27
7/24/2015	6:15:00 AM	0.27
7/24/2015	6:30:00 AM	0.27
7/24/2015	6:45:00 AM	0.27
7/24/2015	7:00:00 AM	0.27
7/24/2015	7:15:00 AM	0.27
7/24/2015	7:30:00 AM	0.27
7/24/2015	7:45:00 AM	0.27
7/24/2015	8:00:00 AM	0.27
7/24/2015	8:15:00 AM	0.27
7/24/2015	8:30:00 AM	0.27
7/24/2015	8:45:00 AM	0.27
7/24/2015	9:00:00 AM	0.27
7/24/2015	9:15:00 AM	0.27
7/24/2015	9:30:00 AM	0.27
7/24/2015	9:45:00 AM	0.27
7/24/2015	10:00:00 AM	0.27
7/24/2015	10:15:00 AM	0.27
7/24/2015	10:30:00 AM	0.27
7/24/2015	10:45:00 AM	0.27
7/24/2015	11:00:00 AM	0.27
7/24/2015	11:15:00 AM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/24/2015	11:30:00 AM	0.27
7/24/2015	11:45:00 AM	0.27
7/24/2015	12:00:00 PM	0.27
7/24/2015	12:15:00 PM	0.27
7/24/2015	12:30:00 PM	0.27
7/24/2015	12:45:00 PM	0.27
7/24/2015	1:00:00 PM	0.27
7/24/2015	1:15:00 PM	0.27
7/24/2015	1:30:00 PM	0.27
7/24/2015	1:45:00 PM	0.27
7/24/2015	2:00:00 PM	0.27
7/24/2015	2:15:00 PM	0.27
7/24/2015	2:30:00 PM	0.27
7/24/2015	2:45:00 PM	0.27
7/24/2015	3:00:00 PM	0.27
7/24/2015	3:15:00 PM	0.27
7/24/2015	3:30:00 PM	0.27
7/24/2015	3:45:00 PM	0.27
7/24/2015	4:00:00 PM	0.27
7/24/2015	4:15:00 PM	0.27
7/24/2015	4:30:00 PM	0.27
7/24/2015	4:45:00 PM	0.27
7/24/2015	5:00:00 PM	0.27
7/24/2015	5:15:00 PM	0.27
7/24/2015	5:30:00 PM	0.27
7/24/2015	5:45:00 PM	0.27
7/24/2015	6:00:00 PM	0.27
7/24/2015	6:15:00 PM	0.27
7/24/2015	6:30:00 PM	0.27
7/24/2015	6:45:00 PM	0.27
7/24/2015	7:00:00 PM	0.27
7/24/2015	7:15:00 PM	0.27
7/24/2015	7:30:00 PM	0.27
7/24/2015	7:45:00 PM	0.27
7/24/2015	8:00:00 PM	0.27
7/24/2015	8:15:00 PM	0.27
7/24/2015	8:30:00 PM	0.27
7/24/2015	8:45:00 PM	0.27
7/24/2015	9:00:00 PM	0.27
7/24/2015	9:15:00 PM	0.27
7/24/2015	9:30:00 PM	0.27
7/24/2015	9:45:00 PM	0.27
7/24/2015	10:00:00 PM	0.27
7/24/2015	10:15:00 PM	0.27
7/24/2015	10:30:00 PM	0.27
7/24/2015	10:45:00 PM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/24/2015	11:00:00 PM	0.27
7/24/2015	11:15:00 PM	0.27
7/24/2015	11:30:00 PM	0.27
7/24/2015	11:45:00 PM	0.27
7/25/2015	12:00:00 AM	0.27
7/25/2015	12:15:00 AM	0.27
7/25/2015	12:30:00 AM	0.27
7/25/2015	12:45:00 AM	0.27
7/25/2015	1:00:00 AM	0.27
7/25/2015	1:15:00 AM	0.27
7/25/2015	1:30:00 AM	0.27
7/25/2015	1:45:00 AM	0.27
7/25/2015	2:00:00 AM	0.27
7/25/2015	2:15:00 AM	0.27
7/25/2015	2:30:00 AM	0.27
7/25/2015	2:45:00 AM	0.27
7/25/2015	3:00:00 AM	0.27
7/25/2015	3:15:00 AM	0.27
7/25/2015	3:30:00 AM	0.27
7/25/2015	3:45:00 AM	0.27
7/25/2015	4:00:00 AM	0.27
7/25/2015	4:15:00 AM	0.27
7/25/2015	4:30:00 AM	0.27
7/25/2015	4:45:00 AM	0.27
7/25/2015	5:00:00 AM	0.27
7/25/2015	5:15:00 AM	0.27
7/25/2015	5:30:00 AM	0.27
7/25/2015	5:45:00 AM	0.27
7/25/2015	6:00:00 AM	0.27
7/25/2015	6:15:00 AM	0.27
7/25/2015	6:30:00 AM	0.27
7/25/2015	6:45:00 AM	0.27
7/25/2015	7:00:00 AM	0.27
7/25/2015	7:15:00 AM	0.27
7/25/2015	7:30:00 AM	0.27
7/25/2015	7:45:00 AM	0.27
7/25/2015	8:00:00 AM	0.27
7/25/2015	8:15:00 AM	0.27
7/25/2015	8:30:00 AM	0.27
7/25/2015	8:45:00 AM	0.27
7/25/2015	9:00:00 AM	0.27
7/25/2015	9:15:00 AM	0.27
7/25/2015	9:30:00 AM	0.27
7/25/2015	9:45:00 AM	0.27
7/25/2015	10:00:00 AM	0.27
7/25/2015	10:15:00 AM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/25/2015	10:30:00 AM	0.27
7/25/2015	10:45:00 AM	0.28
7/25/2015	11:00:00 AM	0.28
7/25/2015	11:15:00 AM	0.28
7/25/2015	11:30:00 AM	0.28
7/25/2015	11:45:00 AM	0.28
7/25/2015	12:00:00 PM	0.28
7/25/2015	12:15:00 PM	0.28
7/25/2015	12:30:00 PM	0.28
7/25/2015	12:45:00 PM	0.28
7/25/2015	1:00:00 PM	0.28
7/25/2015	1:15:00 PM	0.28
7/25/2015	1:30:00 PM	0.28
7/25/2015	1:45:00 PM	0.28
7/25/2015	2:00:00 PM	0.28
7/25/2015	2:15:00 PM	0.28
7/25/2015	2:30:00 PM	0.28
7/25/2015	2:45:00 PM	0.28
7/25/2015	3:00:00 PM	0.28
7/25/2015	3:15:00 PM	0.28
7/25/2015	3:30:00 PM	0.27
7/25/2015	3:45:00 PM	0.27
7/25/2015	4:00:00 PM	0.27
7/25/2015	4:15:00 PM	0.27
7/25/2015	4:30:00 PM	0.27
7/25/2015	4:45:00 PM	0.27
7/25/2015	5:00:00 PM	0.27
7/25/2015	5:15:00 PM	0.27
7/25/2015	5:30:00 PM	0.27
7/25/2015	5:45:00 PM	0.27
7/25/2015	6:00:00 PM	0.27
7/25/2015	6:15:00 PM	0.27
7/25/2015	6:30:00 PM	0.27
7/25/2015	6:45:00 PM	0.27
7/25/2015	7:00:00 PM	0.27
7/25/2015	7:15:00 PM	0.27
7/25/2015	7:30:00 PM	0.27
7/25/2015	7:45:00 PM	0.27
7/25/2015	8:00:00 PM	0.27
7/25/2015	8:15:00 PM	0.27
7/25/2015	8:30:00 PM	0.27
7/25/2015	8:45:00 PM	0.27
7/25/2015	9:00:00 PM	0.27
7/25/2015	9:15:00 PM	0.27
7/25/2015	9:30:00 PM	0.27
7/25/2015	9:45:00 PM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/25/2015	10:00:00 PM	0.27
7/25/2015	10:15:00 PM	0.27
7/25/2015	10:30:00 PM	0.27
7/25/2015	10:45:00 PM	0.27
7/25/2015	11:00:00 PM	0.27
7/25/2015	11:15:00 PM	0.27
7/25/2015	11:30:00 PM	0.27
7/25/2015	11:45:00 PM	0.27
7/26/2015	12:00:00 AM	0.27
7/26/2015	12:15:00 AM	0.27
7/26/2015	12:30:00 AM	0.27
7/26/2015	12:45:00 AM	0.27
7/26/2015	1:00:00 AM	0.27
7/26/2015	1:15:00 AM	0.27
7/26/2015	1:30:00 AM	0.27
7/26/2015	1:45:00 AM	0.27
7/26/2015	2:00:00 AM	0.27
7/26/2015	2:15:00 AM	0.27
7/26/2015	2:30:00 AM	0.27
7/26/2015	2:45:00 AM	0.27
7/26/2015	3:00:00 AM	0.27
7/26/2015	3:15:00 AM	0.27
7/26/2015	3:30:00 AM	0.27
7/26/2015	3:45:00 AM	0.27
7/26/2015	4:00:00 AM	0.27
7/26/2015	4:15:00 AM	0.27
7/26/2015	4:30:00 AM	0.27
7/26/2015	4:45:00 AM	0.27
7/26/2015	5:00:00 AM	0.27
7/26/2015	5:15:00 AM	0.27
7/26/2015	5:30:00 AM	0.27
7/26/2015	5:45:00 AM	0.27
7/26/2015	6:00:00 AM	0.27
7/26/2015	6:15:00 AM	0.27
7/26/2015	6:30:00 AM	0.27
7/26/2015	6:45:00 AM	0.27
7/26/2015	7:00:00 AM	0.27
7/26/2015	7:15:00 AM	0.27
7/26/2015	7:30:00 AM	0.27
7/26/2015	7:45:00 AM	0.27
7/26/2015	8:00:00 AM	0.27
7/26/2015	8:15:00 AM	0.27
7/26/2015	8:30:00 AM	0.27
7/26/2015	8:45:00 AM	0.27
7/26/2015	9:00:00 AM	0.27
7/26/2015	9:15:00 AM	0.27

Billy Lake Return Gage

DATE	TIME	GAGE
7/26/2015	9:30:00 AM	0.27
7/26/2015	9:45:00 AM	0.27
7/26/2015	10:00:00 AM	0.27
7/26/2015	10:15:00 AM	0.27
7/26/2015	10:30:00 AM	0.26
7/26/2015	10:45:00 AM	0.26
7/26/2015	11:00:00 AM	0.26
7/26/2015	11:15:00 AM	0.26
7/26/2015	11:30:00 AM	0.26
7/26/2015	11:45:00 AM	0.26
7/26/2015	12:00:00 PM	0.26
7/26/2015	12:15:00 PM	0.26
7/26/2015	12:30:00 PM	0.26
7/26/2015	12:45:00 PM	0.26
7/26/2015	1:00:00 PM	0.26
7/26/2015	1:15:00 PM	0.26
7/26/2015	1:30:00 PM	0.26
7/26/2015	1:45:00 PM	0.26
7/26/2015	2:00:00 PM	0.26
7/26/2015	2:15:00 PM	0.26
7/26/2015	2:30:00 PM	0.26
7/26/2015	2:45:00 PM	0.26
7/26/2015	3:00:00 PM	0.26
7/26/2015	3:15:00 PM	0.26
7/26/2015	3:30:00 PM	0.26
7/26/2015	3:45:00 PM	0.26
7/26/2015	4:00:00 PM	0.26
7/26/2015	4:15:00 PM	0.26
7/26/2015	4:30:00 PM	0.26
7/26/2015	4:45:00 PM	0.26
7/26/2015	5:00:00 PM	0.26
7/26/2015	5:15:00 PM	0.26
7/26/2015	5:30:00 PM	0.26
7/26/2015	5:45:00 PM	0.25
7/26/2015	6:00:00 PM	0.25
7/26/2015	6:15:00 PM	0.25
7/26/2015	6:30:00 PM	0.25
7/26/2015	6:45:00 PM	0.25
7/26/2015	7:00:00 PM	0.25
7/26/2015	7:15:00 PM	0.25
7/26/2015	7:30:00 PM	0.25
7/26/2015	7:45:00 PM	0.25
7/26/2015	8:00:00 PM	0.25
7/26/2015	8:15:00 PM	0.25
7/26/2015	8:30:00 PM	0.25
7/26/2015	8:45:00 PM	0.25

Billy Lake Return Gage

DATE	TIME	GAGE
7/26/2015	9:00:00 PM	0.25
7/26/2015	9:15:00 PM	0.25
7/26/2015	9:30:00 PM	0.25
7/26/2015	9:45:00 PM	0.25
7/26/2015	10:00:00 PM	0.25
7/26/2015	10:15:00 PM	0.25
7/26/2015	10:30:00 PM	0.25
7/26/2015	10:45:00 PM	0.25
7/26/2015	11:00:00 PM	0.25
7/26/2015	11:15:00 PM	0.25
7/26/2015	11:30:00 PM	0.25
7/26/2015	11:45:00 PM	0.25
7/27/2015	12:00:00 AM	0.25
7/27/2015	12:15:00 AM	0.25
7/27/2015	12:30:00 AM	0.25
7/27/2015	12:45:00 AM	0.25
7/27/2015	1:00:00 AM	0.25
7/27/2015	1:15:00 AM	0.25
7/27/2015	1:30:00 AM	0.25
7/27/2015	1:45:00 AM	0.25
7/27/2015	2:00:00 AM	0.25
7/27/2015	2:15:00 AM	0.25
7/27/2015	2:30:00 AM	0.25
7/27/2015	2:45:00 AM	0.25
7/27/2015	3:00:00 AM	0.25
7/27/2015	3:15:00 AM	0.25
7/27/2015	3:30:00 AM	0.25
7/27/2015	3:45:00 AM	0.25
7/27/2015	4:00:00 AM	0.25
7/27/2015	4:15:00 AM	0.25
7/27/2015	4:30:00 AM	0.25
7/27/2015	4:45:00 AM	0.25
7/27/2015	5:00:00 AM	0.25
7/27/2015	5:15:00 AM	0.25
7/27/2015	5:30:00 AM	0.25
7/27/2015	5:45:00 AM	0.25
7/27/2015	6:00:00 AM	0.25
7/27/2015	6:15:00 AM	0.25
7/27/2015	6:30:00 AM	0.25
7/27/2015	6:45:00 AM	0.25
7/27/2015	7:00:00 AM	0.25
7/27/2015	7:15:00 AM	0.25
7/27/2015	7:30:00 AM	0.25
7/27/2015	7:45:00 AM	0.25
7/27/2015	8:00:00 AM	0.25
7/27/2015	8:15:00 AM	0.25

Billy Lake Return Gage

DATE	TIME	GAGE
7/27/2015	8:30:00 AM	0.25
7/27/2015	8:45:00 AM	0.25
7/27/2015	9:00:00 AM	0.25
7/27/2015	9:15:00 AM	0.25
7/27/2015	9:30:00 AM	0.25
7/27/2015	9:45:00 AM	0.25
7/27/2015	10:00:00 AM	0.25
7/27/2015	10:15:00 AM	0.25
7/27/2015	10:30:00 AM	0.25
7/27/2015	10:45:00 AM	0.24
7/27/2015	11:00:00 AM	0.24
7/27/2015	11:15:00 AM	0.24
7/27/2015	11:30:00 AM	0.24
7/27/2015	11:45:00 AM	0.24
7/27/2015	12:00:00 PM	0.24
7/27/2015	12:15:00 PM	0.24
7/27/2015	12:30:00 PM	0.24
7/27/2015	12:45:00 PM	0.24
7/27/2015	1:00:00 PM	0.24
7/27/2015	1:15:00 PM	0.24
7/27/2015	1:30:00 PM	0.24
7/27/2015	1:45:00 PM	0.24
7/27/2015	2:00:00 PM	0.24
7/27/2015	2:15:00 PM	0.24
7/27/2015	2:30:00 PM	0.24
7/27/2015	2:45:00 PM	0.24
7/27/2015	3:00:00 PM	0.24
7/27/2015	3:15:00 PM	0.24
7/27/2015	3:30:00 PM	0.24
7/27/2015	3:45:00 PM	0.24
7/27/2015	4:00:00 PM	0.24
7/27/2015	4:15:00 PM	0.24
7/27/2015	4:30:00 PM	0.24
7/27/2015	4:45:00 PM	0.23
7/27/2015	5:00:00 PM	0.23
7/27/2015	5:15:00 PM	0.23
7/27/2015	5:30:00 PM	0.23
7/27/2015	5:45:00 PM	0.23
7/27/2015	6:00:00 PM	0.23
7/27/2015	6:15:00 PM	0.23
7/27/2015	6:30:00 PM	0.23
7/27/2015	6:45:00 PM	0.23
7/27/2015	7:00:00 PM	0.23
7/27/2015	7:15:00 PM	0.23
7/27/2015	7:30:00 PM	0.23
7/27/2015	7:45:00 PM	0.23

Billy Lake Return Gage

DATE	TIME	GAGE
7/27/2015	8:00:00 PM	0.23
7/27/2015	8:15:00 PM	0.23
7/27/2015	8:30:00 PM	0.23
7/27/2015	8:45:00 PM	0.23
7/27/2015	9:00:00 PM	0.23
7/27/2015	9:15:00 PM	0.23
7/27/2015	9:30:00 PM	0.23
7/27/2015	9:45:00 PM	0.23
7/27/2015	10:00:00 PM	0.23
7/27/2015	10:15:00 PM	0.23
7/27/2015	10:30:00 PM	0.23
7/27/2015	10:45:00 PM	0.23
7/27/2015	11:00:00 PM	0.23
7/27/2015	11:15:00 PM	0.23
7/27/2015	11:30:00 PM	0.23
7/27/2015	11:45:00 PM	0.23
7/28/2015	12:00:00 AM	0.23
7/28/2015	12:15:00 AM	0.23
7/28/2015	12:30:00 AM	0.23
7/28/2015	12:45:00 AM	0.23
7/28/2015	1:00:00 AM	0.23
7/28/2015	1:15:00 AM	0.23
7/28/2015	1:30:00 AM	0.23
7/28/2015	1:45:00 AM	0.23
7/28/2015	2:00:00 AM	0.23
7/28/2015	2:15:00 AM	0.23
7/28/2015	2:30:00 AM	0.23
7/28/2015	2:45:00 AM	0.23
7/28/2015	3:00:00 AM	0.23
7/28/2015	3:15:00 AM	0.23
7/28/2015	3:30:00 AM	0.23
7/28/2015	3:45:00 AM	0.23
7/28/2015	4:00:00 AM	0.23
7/28/2015	4:15:00 AM	0.23
7/28/2015	4:30:00 AM	0.23
7/28/2015	4:45:00 AM	0.23
7/28/2015	5:00:00 AM	0.23
7/28/2015	5:15:00 AM	0.23
7/28/2015	5:30:00 AM	0.23
7/28/2015	5:45:00 AM	0.23
7/28/2015	6:00:00 AM	0.23
7/28/2015	6:15:00 AM	0.23
7/28/2015	6:30:00 AM	0.23
7/28/2015	6:45:00 AM	0.23
7/28/2015	7:00:00 AM	0.23
7/28/2015	7:15:00 AM	0.23

Billy Lake Return Gage

DATE	TIME	GAGE
7/28/2015	7:30:00 AM	0.23
7/28/2015	7:45:00 AM	0.23
7/28/2015	8:00:00 AM	0.23
7/28/2015	8:15:00 AM	0.23
7/28/2015	8:30:00 AM	0.23
7/28/2015	8:45:00 AM	0.23
7/28/2015	9:00:00 AM	0.23
7/28/2015	9:15:00 AM	0.23
7/28/2015	9:30:00 AM	0.23
7/28/2015	9:45:00 AM	0.23
7/28/2015	10:00:00 AM	0.23
7/28/2015	10:15:00 AM	0.22
7/28/2015	10:30:00 AM	0.22
7/28/2015	10:45:00 AM	0.22
7/28/2015	11:00:00 AM	0.22
7/28/2015	11:15:00 AM	0.22
7/28/2015	11:30:00 AM	0.22
7/28/2015	11:45:00 AM	0.22
7/28/2015	12:00:00 PM	0.22
7/28/2015	12:15:00 PM	0.22
7/28/2015	12:30:00 PM	0.22
7/28/2015	12:45:00 PM	0.22
7/28/2015	1:00:00 PM	0.22
7/28/2015	1:15:00 PM	0.22
7/28/2015	1:30:00 PM	0.22
7/28/2015	1:45:00 PM	0.22
7/28/2015	2:00:00 PM	0.22
7/28/2015	2:15:00 PM	0.22
7/28/2015	2:30:00 PM	0.22
7/28/2015	2:45:00 PM	0.22
7/28/2015	3:00:00 PM	0.22
7/28/2015	3:15:00 PM	0.22
7/28/2015	3:30:00 PM	0.22
7/28/2015	3:45:00 PM	0.22
7/28/2015	4:00:00 PM	0.22
7/28/2015	4:15:00 PM	0.21
7/28/2015	4:30:00 PM	0.21
7/28/2015	4:45:00 PM	0.21
7/28/2015	5:00:00 PM	0.21
7/28/2015	5:15:00 PM	0.21
7/28/2015	5:30:00 PM	0.21
7/28/2015	5:45:00 PM	0.21
7/28/2015	6:00:00 PM	0.21
7/28/2015	6:15:00 PM	0.21
7/28/2015	6:30:00 PM	0.21
7/28/2015	6:45:00 PM	0.21

Billy Lake Return Gage

DATE	TIME	GAGE
7/28/2015	7:00:00 PM	0.21
7/28/2015	7:15:00 PM	0.21
7/28/2015	7:30:00 PM	0.21
7/28/2015	7:45:00 PM	0.21
7/28/2015	8:00:00 PM	0.21
7/28/2015	8:15:00 PM	0.21
7/28/2015	8:30:00 PM	0.21
7/28/2015	8:45:00 PM	0.21
7/28/2015	9:00:00 PM	0.21
7/28/2015	9:15:00 PM	0.21
7/28/2015	9:30:00 PM	0.21
7/28/2015	9:45:00 PM	0.21
7/28/2015	10:00:00 PM	0.21
7/28/2015	10:15:00 PM	0.21
7/28/2015	10:30:00 PM	0.21
7/28/2015	10:45:00 PM	0.21
7/28/2015	11:00:00 PM	0.21
7/28/2015	11:15:00 PM	0.21
7/28/2015	11:30:00 PM	0.21
7/28/2015	11:45:00 PM	0.21
7/29/2015	12:00:00 AM	0.21
7/29/2015	12:15:00 AM	0.21
7/29/2015	12:30:00 AM	0.21
7/29/2015	12:45:00 AM	0.21
7/29/2015	1:00:00 AM	0.21
7/29/2015	1:15:00 AM	0.21
7/29/2015	1:30:00 AM	0.21
7/29/2015	1:45:00 AM	0.21
7/29/2015	2:00:00 AM	0.21
7/29/2015	2:15:00 AM	0.21
7/29/2015	2:30:00 AM	0.21
7/29/2015	2:45:00 AM	0.21
7/29/2015	3:00:00 AM	0.21
7/29/2015	3:15:00 AM	0.21
7/29/2015	3:30:00 AM	0.21
7/29/2015	3:45:00 AM	0.21
7/29/2015	4:00:00 AM	0.21
7/29/2015	4:15:00 AM	0.22
7/29/2015	4:30:00 AM	0.22
7/29/2015	4:45:00 AM	0.22
7/29/2015	5:00:00 AM	0.22
7/29/2015	5:15:00 AM	0.22
7/29/2015	5:30:00 AM	0.22
7/29/2015	5:45:00 AM	0.22
7/29/2015	6:00:00 AM	0.22
7/29/2015	6:15:00 AM	0.22

Billy Lake Return Gage

DATE	TIME	GAGE
7/29/2015	6:30:00 AM	0.22
7/29/2015	6:45:00 AM	0.22
7/29/2015	7:00:00 AM	0.22
7/29/2015	7:15:00 AM	0.22
7/29/2015	7:30:00 AM	0.22
7/29/2015	7:45:00 AM	0.22
7/29/2015	8:00:00 AM	0.22
7/29/2015	8:15:00 AM	0.22
7/29/2015	8:30:00 AM	0.22
7/29/2015	8:45:00 AM	0.22
7/29/2015	9:00:00 AM	0.22
7/29/2015	9:15:00 AM	0.23
7/29/2015	9:30:00 AM	0.23
7/29/2015	9:45:00 AM	0.23
7/29/2015	10:00:00 AM	0.23
7/29/2015	10:15:00 AM	0.23
7/29/2015	10:30:00 AM	0.23
7/29/2015	10:45:00 AM	0.23
7/29/2015	11:00:00 AM	0.23
7/29/2015	11:15:00 AM	0.23
7/29/2015	11:30:00 AM	0.23
7/29/2015	11:45:00 AM	0.23
7/29/2015	12:00:00 PM	0.23
7/29/2015	12:15:00 PM	0.23
7/29/2015	12:30:00 PM	0.23
7/29/2015	12:45:00 PM	0.23
7/29/2015	1:00:00 PM	0.23
7/29/2015	1:15:00 PM	0.23
7/29/2015	1:30:00 PM	0.23
7/29/2015	1:45:00 PM	0.23
7/29/2015	2:00:00 PM	0.23
7/29/2015	2:15:00 PM	0.23
7/29/2015	2:30:00 PM	0.23
7/29/2015	2:45:00 PM	0.23
7/29/2015	3:00:00 PM	0.23
7/29/2015	3:15:00 PM	0.23
7/29/2015	3:30:00 PM	0.23
7/29/2015	3:45:00 PM	0.23
7/29/2015	4:00:00 PM	0.23
7/29/2015	4:15:00 PM	0.23
7/29/2015	4:30:00 PM	0.23
7/29/2015	4:45:00 PM	0.23
7/29/2015	5:00:00 PM	0.23
7/29/2015	5:15:00 PM	0.23
7/29/2015	5:30:00 PM	0.23
7/29/2015	5:45:00 PM	0.23

Billy Lake Return Gage

DATE	TIME	GAGE
7/29/2015	6:00:00 PM	0.24
7/29/2015	6:15:00 PM	0.24
7/29/2015	6:30:00 PM	0.24
7/29/2015	6:45:00 PM	0.24
7/29/2015	7:00:00 PM	0.24
7/29/2015	7:15:00 PM	0.24
7/29/2015	7:30:00 PM	0.24
7/29/2015	7:45:00 PM	0.24
7/29/2015	8:00:00 PM	0.24
7/29/2015	8:15:00 PM	0.24
7/29/2015	8:30:00 PM	0.24
7/29/2015	8:45:00 PM	0.24
7/29/2015	9:00:00 PM	0.24
7/29/2015	9:15:00 PM	0.24
7/29/2015	9:30:00 PM	0.24
7/29/2015	9:45:00 PM	0.24
7/29/2015	10:00:00 PM	0.24
7/29/2015	10:15:00 PM	0.24
7/29/2015	10:30:00 PM	0.24
7/29/2015	10:45:00 PM	0.24
7/29/2015	11:00:00 PM	0.24
7/29/2015	11:15:00 PM	0.24
7/29/2015	11:30:00 PM	0.24
7/29/2015	11:45:00 PM	0.24
7/30/2015	12:00:00 AM	0.24
7/30/2015	12:15:00 AM	0.24
7/30/2015	12:30:00 AM	0.24
7/30/2015	12:45:00 AM	0.25
7/30/2015	1:00:00 AM	0.25
7/30/2015	1:15:00 AM	0.25
7/30/2015	1:30:00 AM	0.25
7/30/2015	1:45:00 AM	0.25
7/30/2015	2:00:00 AM	0.25
7/30/2015	2:15:00 AM	0.25
7/30/2015	2:30:00 AM	0.25
7/30/2015	2:45:00 AM	0.25
7/30/2015	3:00:00 AM	0.25
7/30/2015	3:15:00 AM	0.25
7/30/2015	3:30:00 AM	0.25
7/30/2015	3:45:00 AM	0.25
7/30/2015	4:00:00 AM	0.25
7/30/2015	4:15:00 AM	0.25
7/30/2015	4:30:00 AM	0.26
7/30/2015	4:45:00 AM	0.26
7/30/2015	5:00:00 AM	0.26
7/30/2015	5:15:00 AM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
7/30/2015	5:30:00 AM	0.26
7/30/2015	5:45:00 AM	0.26
7/30/2015	6:00:00 AM	0.26
7/30/2015	6:15:00 AM	0.26
7/30/2015	6:30:00 AM	0.26
7/30/2015	6:45:00 AM	0.26
7/30/2015	7:00:00 AM	0.26
7/30/2015	7:15:00 AM	0.26
7/30/2015	7:30:00 AM	0.26
7/30/2015	7:45:00 AM	0.26
7/30/2015	8:00:00 AM	0.26
7/30/2015	8:15:00 AM	0.26
7/30/2015	8:30:00 AM	0.26
7/30/2015	8:45:00 AM	0.26
7/30/2015	9:00:00 AM	0.26
7/30/2015	9:15:00 AM	0.26
7/30/2015	9:30:00 AM	0.26
7/30/2015	9:45:00 AM	0.26
7/30/2015	10:00:00 AM	0.26
7/30/2015	10:15:00 AM	0.26
7/30/2015	10:30:00 AM	0.26
7/30/2015	10:45:00 AM	0.26
7/30/2015	11:00:00 AM	0.26
7/30/2015	11:15:00 AM	0.26
7/30/2015	11:30:00 AM	0.26
7/30/2015	11:45:00 AM	0.26
7/30/2015	12:00:00 PM	0.26
7/30/2015	12:15:00 PM	0.26
7/30/2015	12:30:00 PM	0.26
7/30/2015	12:45:00 PM	0.26
7/30/2015	1:00:00 PM	0.26
7/30/2015	1:15:00 PM	0.26
7/30/2015	1:30:00 PM	0.26
7/30/2015	1:45:00 PM	0.26
7/30/2015	2:00:00 PM	0.26
7/30/2015	2:15:00 PM	0.26
7/30/2015	2:30:00 PM	0.26
7/30/2015	2:45:00 PM	0.26
7/30/2015	3:00:00 PM	0.26
7/30/2015	3:15:00 PM	0.26
7/30/2015	3:30:00 PM	0.26
7/30/2015	3:45:00 PM	0.26
7/30/2015	4:00:00 PM	0.26
7/30/2015	4:15:00 PM	0.26
7/30/2015	4:30:00 PM	0.26
7/30/2015	4:45:00 PM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
7/30/2015	5:00:00 PM	0.26
7/30/2015	5:15:00 PM	0.26
7/30/2015	5:30:00 PM	0.26
7/30/2015	5:45:00 PM	0.26
7/30/2015	6:00:00 PM	0.26
7/30/2015	6:15:00 PM	0.26
7/30/2015	6:30:00 PM	0.26
7/30/2015	6:45:00 PM	0.26
7/30/2015	7:00:00 PM	0.26
7/30/2015	7:15:00 PM	0.26
7/30/2015	7:30:00 PM	0.26
7/30/2015	7:45:00 PM	0.26
7/30/2015	8:00:00 PM	0.26
7/30/2015	8:15:00 PM	0.26
7/30/2015	8:30:00 PM	0.26
7/30/2015	8:45:00 PM	0.26
7/30/2015	9:00:00 PM	0.26
7/30/2015	9:15:00 PM	0.26
7/30/2015	9:30:00 PM	0.26
7/30/2015	9:45:00 PM	0.26
7/30/2015	10:00:00 PM	0.26
7/30/2015	10:15:00 PM	0.26
7/30/2015	10:30:00 PM	0.26
7/30/2015	10:45:00 PM	0.26
7/30/2015	11:00:00 PM	0.26
7/30/2015	11:15:00 PM	0.26
7/30/2015	11:30:00 PM	0.26
7/30/2015	11:45:00 PM	0.26
7/31/2015	12:00:00 AM	0.26
7/31/2015	12:15:00 AM	0.26
7/31/2015	12:30:00 AM	0.26
7/31/2015	12:45:00 AM	0.26
7/31/2015	1:00:00 AM	0.26
7/31/2015	1:15:00 AM	0.26
7/31/2015	1:30:00 AM	0.26
7/31/2015	1:45:00 AM	0.26
7/31/2015	2:00:00 AM	0.26
7/31/2015	2:15:00 AM	0.26
7/31/2015	2:30:00 AM	0.26
7/31/2015	2:45:00 AM	0.26
7/31/2015	3:00:00 AM	0.26
7/31/2015	3:15:00 AM	0.26
7/31/2015	3:30:00 AM	0.26
7/31/2015	3:45:00 AM	0.26
7/31/2015	4:00:00 AM	0.26
7/31/2015	4:15:00 AM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
7/31/2015	4:30:00 AM	0.26
7/31/2015	4:45:00 AM	0.26
7/31/2015	5:00:00 AM	0.26
7/31/2015	5:15:00 AM	0.26
7/31/2015	5:30:00 AM	0.26
7/31/2015	5:45:00 AM	0.26
7/31/2015	6:00:00 AM	0.26
7/31/2015	6:15:00 AM	0.26
7/31/2015	6:30:00 AM	0.26
7/31/2015	6:45:00 AM	0.26
7/31/2015	7:00:00 AM	0.26
7/31/2015	7:15:00 AM	0.26
7/31/2015	7:30:00 AM	0.26
7/31/2015	7:45:00 AM	0.26
7/31/2015	8:00:00 AM	0.26
7/31/2015	8:15:00 AM	0.26
7/31/2015	8:30:00 AM	0.26
7/31/2015	8:45:00 AM	0.26
7/31/2015	9:00:00 AM	0.26
7/31/2015	9:15:00 AM	0.26
7/31/2015	9:30:00 AM	0.26
7/31/2015	9:45:00 AM	0.26
7/31/2015	10:00:00 AM	0.26
7/31/2015	10:15:00 AM	0.26
7/31/2015	10:30:00 AM	0.26
7/31/2015	10:45:00 AM	0.26
7/31/2015	11:00:00 AM	0.26
7/31/2015	11:15:00 AM	0.26
7/31/2015	11:30:00 AM	0.26
7/31/2015	11:45:00 AM	0.26
7/31/2015	12:00:00 PM	0.26
7/31/2015	12:15:00 PM	0.26
7/31/2015	12:30:00 PM	0.26
7/31/2015	12:45:00 PM	0.26
7/31/2015	1:00:00 PM	0.26
7/31/2015	1:15:00 PM	0.26
7/31/2015	1:30:00 PM	0.26
7/31/2015	1:45:00 PM	0.26
7/31/2015	2:00:00 PM	0.26
7/31/2015	2:15:00 PM	0.26
7/31/2015	2:30:00 PM	0.26
7/31/2015	2:45:00 PM	0.26
7/31/2015	3:00:00 PM	0.26
7/31/2015	3:15:00 PM	0.26
7/31/2015	3:30:00 PM	0.26
7/31/2015	3:45:00 PM	0.26

Billy Lake Return Gage

DATE	TIME	GAGE
7/31/2015	4:00:00 PM	0.26
7/31/2015	4:15:00 PM	0.26
7/31/2015	4:30:00 PM	0.26
7/31/2015	4:45:00 PM	0.26
7/31/2015	5:00:00 PM	0.26
7/31/2015	5:15:00 PM	0.26
7/31/2015	5:30:00 PM	0.26
7/31/2015	5:45:00 PM	0.26
7/31/2015	6:00:00 PM	0.26
7/31/2015	6:15:00 PM	0.26
7/31/2015	6:30:00 PM	0.26
7/31/2015	6:45:00 PM	0.26
7/31/2015	7:00:00 PM	0.26
7/31/2015	7:15:00 PM	0.26
7/31/2015	7:30:00 PM	0.26
7/31/2015	7:45:00 PM	0.26
7/31/2015	8:00:00 PM	0.26
7/31/2015	8:15:00 PM	0.26
7/31/2015	8:30:00 PM	0.26
7/31/2015	8:45:00 PM	0.26
7/31/2015	9:00:00 PM	0.26
7/31/2015	9:15:00 PM	0.26
7/31/2015	9:30:00 PM	0.26
7/31/2015	9:45:00 PM	0.26
7/31/2015	10:00:00 PM	0.26
7/31/2015	10:15:00 PM	0.26
7/31/2015	10:30:00 PM	0.26
7/31/2015	10:45:00 PM	0.26
7/31/2015	11:00:00 PM	0.26
7/31/2015	11:15:00 PM	0.26
7/31/2015	11:30:00 PM	0.26
7/31/2015	11:45:00 PM	0.26

Party: MKH / PLL	Width: 21.3 ft	Processed by: MKH
Boat/Motor:	Area: 82.8 ft ²	Mean Velocity: 0.599 ft/s
Gage Height: 4.30 ft	G.H.Change: 0.000 ft	Discharge: 49.6 ft ³ /s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.0°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft ²	Diff.: 0.000%
Depth Sounder: Not Used	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:	ADCP:
BT 3-Beam Solution: NO	Type/Freq.: StreamPro / 2000 kHz
WT 3-Beam Solution: NO	Serial #: Firmware: 31.12
BT Error Vel.: 32.81 ft/s	Bin Size: 10 cm Blank: 3 cm
WT Error Vel.: 32.81 ft/s	BT Mode: 10 BT Pings: 2
BT Up Vel.: 32.81 ft/s	WT Mode: 12 WT Pings: 6
WT Up Vel.: 32.81 ft/s	WV : 0 WO : 1, 4
Use Weighted Mean Depth: NO	
Max. Vel.: 2.13 ft/s	
Max. Depth: 6.40 ft	
Mean Depth: 3.89 ft	
% Meas.: 66.50	
Water Temp.: None	
ADCP Temp.: 68.2 °F	

Performed Diag. Test: NO
 Performed Moving Bed Test: NO
 Performed Compass Calibration: NO Evaluation: NO
 Meas. Location:

Project Name: 150722 LOR @ MAZOURKA_0
 Software: 2.11

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	L	2	2	37	6.14	30.9	6.75	1.77	1.91	47.5	21	82	07:09	07:09	0.51	0.58	5	0
001	R	2	2	35	6.82	34.4	6.85	1.77	1.91	51.7	21	82	07:10	07:10	0.54	0.63	6	0
002	L	2	2	35	6.82	34.5	6.85	1.52	1.52	51.2	21	83	07:11	07:11	0.52	0.61	6	0
003	R	2	2	34	6.85	34.7	6.64	1.66	1.84	51.7	22	84	07:12	07:13	0.55	0.61	6	0
004	L	2	2	34	6.25	31.6	6.32	1.77	1.80	47.8	21	82	07:13	07:14	0.52	0.58	6	0
005	R	2	2	37	6.25	31.7	6.50	1.59	1.70	47.8	21	83	07:14	07:15	0.49	0.58	5	0
Mean		2	2	35	6.52	33.0	6.65	1.68	1.78	49.6	21	83	Total	00:05	0.52	0.60	6	0
SDev		0	0	1	0.338	1.73	0.210	0.107	0.149	2.13	0.3	0.8			0.02	0.02		
SD/M		0.00	0.00	0.04	0.05	0.05	0.03	0.06	0.08	0.04	0.01	0.01			0.04	0.04		

Remarks:

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	1	0	4	8	0.666	-0.052	3.894	0.01	0.007	0	47.3	44.7	65.8	144	136	0	34	32
2015	7	1	0	14	8	0.702	-0.072	3.894	0.016	0.013	0	47.3	44.7	63.6	144	136	0	34	32
2015	7	1	0	24	8	0.659	-0.095	3.894	0.01	0.007	0	46.4	43.4	60.6	142	134	0	34	33
2015	7	1	0	34	8	0.686	-0.085	3.898	0.01	0.007	0	47.3	43.9	57.2	144	135	0	34	33
2015	7	1	0	44	8	0.636	-0.085	3.898	0.013	0.01	0	47.7	44.7	63.2	144	136	0	33	32
2015	7	1	0	54	8	0.689	-0.069	3.898	0.013	0.01	0	47.3	44.3	67.1	144	136	0	34	33
2015	7	1	1	4	8	0.669	-0.072	3.898	0.01	0.007	0	47.7	43.9	67.1	144	135	0	33	33
2015	7	1	1	14	8	0.636	-0.089	3.898	0.013	0.01	0	47.7	44.7	67.5	144	136	0	33	32
2015	7	1	1	24	8	0.663	-0.052	3.901	0.01	0.007	0	47.3	44.3	63.6	143	135	0	33	32
2015	7	1	1	34	8	0.653	-0.079	3.901	0.01	0.007	0	47.7	44.7	67.9	144	136	0	33	32
2015	7	1	1	44	8	0.692	-0.079	3.901	0.01	0.007	0	47.3	44.7	61.9	143	136	0	33	32
2015	7	1	1	54	8	0.686	-0.072	3.901	0.01	0.007	0	47.3	43.9	60.6	144	135	0	34	33
2015	7	1	2	4	8	0.696	-0.092	3.901	0.01	0.007	0	47.7	44.7	66.2	144	136	0	33	32
2015	7	1	2	14	8	0.653	-0.089	3.901	0.01	0.007	0	47.7	44.7	68.8	145	136	0	34	32
2015	7	1	2	24	8	0.696	-0.075	3.901	0.01	0.007	0	47.3	44.7	67.5	144	136	0	34	32
2015	7	1	2	34	8	0.682	-0.066	3.901	0.013	0.01	0	48.2	44.7	58.9	145	137	0	33	33
2015	7	1	2	44	8	0.646	-0.089	3.904	0.016	0.016	0	47.3	44.7	62.4	144	136	0	34	32
2015	7	1	2	54	8	0.692	-0.069	3.904	0.01	0.007	0	47.7	45.6	63.6	145	137	0	34	31
2015	7	1	3	4	8	0.679	-0.043	3.904	0.01	0.007	0	48.6	45.6	57.6	146	139	0	33	33
2015	7	1	3	14	8	0.679	-0.075	3.904	0.01	0.007	0	47.7	44.7	52	145	136	0	34	32
2015	7	1	3	24	8	0.696	-0.092	3.904	0.01	0.007	0	47.3	44.3	55	144	136	0	34	33
2015	7	1	3	34	8	0.63	-0.079	3.904	0.016	0.013	0	47.7	44.7	62.4	145	137	0	34	33
2015	7	1	3	44	8	0.709	-0.121	3.904	0.01	0.007	0	48.2	45.2	59.3	145	137	0	33	32
2015	7	1	3	54	8	0.636	-0.069	3.904	0.013	0.01	0	48.2	44.7	55.5	145	136	0	33	32
2015	7	1	4	4	8	0.65	-0.066	3.904	0.013	0.01	0	47.7	45.2	61.1	145	137	0	34	32
2015	7	1	4	14	8	0.656	-0.066	3.904	0.013	0.01	0	47.7	44.7	65.4	145	137	0	34	33
2015	7	1	4	24	8	0.65	-0.036	3.904	0.016	0.013	0	47.7	44.7	67.5	144	137	0	33	33
2015	7	1	4	34	8	0.682	-0.075	3.907	0.013	0.01	0	47.3	44.7	68.4	145	136	0	35	32
2015	7	1	4	44	8	0.699	-0.082	3.907	0.01	0.007	0	47.7	44.7	69.7	145	137	0	34	33
2015	7	1	4	54	8	0.679	-0.118	3.907	0.016	0.013	0	46.9	44.3	67.9	143	135	0	34	32
2015	7	1	5	4	8	0.676	-0.085	3.907	0.01	0.007	0	47.7	44.7	68.4	145	137	0	34	33
2015	7	1	5	14	8	0.673	-0.066	3.907	0.01	0.007	0	47.7	44.3	67.5	145	136	0	34	33
2015	7	1	5	24	8	0.666	-0.072	3.907	0.016	0.016	0	47.3	44.7	67.1	144	136	0	34	32
2015	7	1	5	34	8	0.636	-0.046	3.907	0.013	0.01	0	48.2	45.2	70.1	146	137	0	34	32
2015	7	1	5	44	8	0.676	-0.092	3.907	0.01	0.007	0	47.3	44.3	69.2	144	136	0	34	33
2015	7	1	5	54	8	0.679	-0.056	3.911	0.013	0.01	0	47.7	44.7	49.9	145	137	0	34	33
2015	7	1	6	4	8	0.679	-0.085	3.904	0.013	0.01	0	54.2	51.6	44.3	160	152	0	34	32
2015	7	1	6	14	8	0.722	-0.052	3.907	0.01	0.007	0	56.3	52.9	42.1	164	156	0	33	33
2015	7	1	6	24	8	0.653	-0.069	3.911	0.013	0.01	0	54.6	51.6	43	161	153	0	34	33
2015	7	1	6	34	8	0.673	-0.052	3.917	0.013	0.01	0	53.8	51.2	45.6	159	151	0	34	32
2015	7	1	6	44	8	0.659	-0.066	3.917	0.01	0.007	0	53.3	49.9	46.4	158	149	0	34	33
2015	7	1	6	54	8	0.692	-0.072	3.917	0.013	0.01	0	51.6	48.2	46	154	145	0	34	33
2015	7	1	7	4	8	0.692	-0.092	3.917	0.013	0.01	0	50.7	47.3	47.3	151	142	0	33	32
2015	7	1	7	14	8	0.686	-0.118	3.921	0.016	0.013	0	49.9	46.4	47.3	150	140	0	34	32
2015	7	1	7	24	8	0.633	-0.02	3.917	0.013	0.01	0	49.5	46	49.9	149	139	0	34	32
2015	7	1	7	34	8	0.643	-0.052	3.921	0.01	0.007	0	49	45.6	48.6	147	138	0	33	32
2015	7	1	7	44	8	0.643	-0.052	3.917	0.013	0.01	0	48.6	45.6	48.2	147	138	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	1	7	54	8	0.666	-0.049	3.921	0.01	0.007	0	48.2	44.7	49.5	145	136	0	33	32
2015	7	1	8	4	8	0.692	-0.082	3.921	0.01	0.007	0	47.7	43.9	49.5	145	135	0	34	33
2015	7	1	8	14	8	0.653	-0.062	3.921	0.01	0.007	0	47.7	43.9	49.9	145	135	0	34	33
2015	7	1	8	24	8	0.673	-0.098	3.921	0.01	0.007	0	47.3	44.3	50.3	144	135	0	34	32
2015	7	1	8	34	8	0.656	-0.075	3.921	0.013	0.01	0	47.3	43.9	51.2	144	135	0	34	33
2015	7	1	8	44	8	0.686	-0.085	3.921	0.01	0.007	0	47.3	43.4	47.3	143	134	0	33	33
2015	7	1	8	54	8	0.686	-0.085	3.921	0.01	0.007	0	46.9	43.4	53.8	143	134	0	34	33
2015	7	1	9	4	8	0.725	-0.082	3.917	0.01	0.007	0	47.3	43.9	52.9	143	133	0	33	31
2015	7	1	9	14	8	0.676	-0.105	3.917	0.013	0.01	0	46.9	43.9	54.2	143	134	0	34	32
2015	7	1	9	24	8	0.699	-0.082	3.921	0.016	0.013	0	46.4	43	55.9	142	133	0	34	33
2015	7	1	9	34	8	0.686	-0.069	3.917	0.01	0.007	0	46.4	43.4	58	142	133	0	34	32
2015	7	1	9	44	8	0.686	-0.105	3.921	0.01	0.007	0	46.9	43.9	57.6	143	134	0	34	32
2015	7	1	9	54	8	0.663	-0.105	3.921	0.01	0.007	0	47.3	43.9	61.5	143	134	0	33	32
2015	7	1	10	4	8	0.673	-0.066	3.921	0.01	0.007	0	48.2	44.7	63.6	146	137	0	34	33
2015	7	1	10	14	8	0.689	-0.085	3.924	0.013	0.01	0	48.6	45.2	62.8	146	137	0	33	32
2015	7	1	10	24	8	0.689	-0.052	3.927	0.01	0.007	0	47.7	44.7	63.6	145	136	0	34	32
2015	7	1	10	34	8	0.692	-0.043	3.927	0.013	0.01	0	47.3	43.4	64.9	144	134	0	34	33
2015	7	1	10	44	8	0.676	-0.01	3.93	0.013	0.01	0	47.3	44.3	59.3	144	135	0	34	32
2015	7	1	10	54	8	0.692	-0.075	3.93	0.013	0.01	0	47.7	43.9	54.2	144	135	0	33	33
2015	7	1	11	4	8	0.669	-0.069	3.93	0.01	0.007	0	48.2	44.7	64.9	146	137	0	34	33
2015	7	1	11	14	8	0.689	-0.092	3.93	0.013	0.01	0	48.2	45.2	64.5	146	137	0	34	32
2015	7	1	11	24	8	0.682	-0.052	3.93	0.01	0.007	0	48.2	43.9	61.1	145	135	0	33	33
2015	7	1	11	34	8	0.676	-0.052	3.93	0.01	0.007	0	47.3	44.3	60.6	144	135	0	34	32
2015	7	1	11	44	8	0.686	-0.105	3.93	0.01	0.007	0	47.3	43.9	56.3	143	135	0	33	33
2015	7	1	11	54	8	0.676	-0.066	3.934	0.01	0.007	0	47.3	43.4	67.5	143	134	0	33	33
2015	7	1	12	4	8	0.673	-0.082	3.934	0.013	0.01	0	47.3	43.4	61.1	143	134	0	33	33
2015	7	1	12	14	8	0.689	-0.092	3.934	0.01	0.007	0	46.4	43	58	142	133	0	34	33
2015	7	1	12	24	8	0.686	-0.095	3.934	0.01	0.007	0	46.9	43.4	69.2	142	133	0	33	32
2015	7	1	12	34	8	0.702	-0.089	3.934	0.01	0.007	0	46.4	43	68.8	142	133	0	34	33
2015	7	1	12	44	8	0.666	-0.085	3.934	0.01	0.007	0	46.4	43.4	66.2	142	133	0	34	32
2015	7	1	12	54	8	0.715	-0.082	3.934	0.01	0.007	0	46	42.6	53.8	141	132	0	34	33
2015	7	1	13	4	8	0.692	-0.105	3.934	0.013	0.01	0	46.4	42.6	63.2	141	132	0	33	33
2015	7	1	13	14	8	0.659	-0.108	3.934	0.01	0.007	0	46.4	43	67.1	141	132	0	33	32
2015	7	1	13	24	8	0.673	-0.098	3.934	0.013	0.01	0	46.4	43.4	68.4	142	133	0	34	32
2015	7	1	13	34	8	0.669	-0.089	3.934	0.01	0.007	0	46	43	69.7	141	133	0	34	33
2015	7	1	13	44	8	0.692	-0.069	3.934	0.013	0.01	0	46.4	42.6	63.2	141	132	0	33	33
2015	7	1	13	54	8	0.699	-0.105	3.934	0.01	0.007	0	46.9	43.4	68.8	142	133	0	33	32
2015	7	1	14	4	8	0.686	-0.128	3.937	0.01	0.007	0	45.6	42.6	69.2	140	131	0	34	32
2015	7	1	14	14	8	0.686	-0.112	3.937	0.013	0.01	0	45.2	42.1	69.7	138	130	0	33	32
2015	7	1	14	24	8	0.692	-0.138	3.934	0.013	0.01	0	44.3	41.3	68.4	137	129	0	34	33
2015	7	1	14	34	8	0.659	-0.125	3.934	0.016	0.013	0	44.3	41.3	59.8	137	128	0	34	32
2015	7	1	14	44	8	0.676	-0.138	3.934	0.013	0.01	0	44.3	41.3	61.1	137	128	0	34	32
2015	7	1	14	54	8	0.669	-0.112	3.934	0.01	0.007	0	44.7	40.9	68.8	137	128	0	33	33
2015	7	1	15	4	8	0.676	-0.085	3.934	0.01	0.007	0	44.3	41.3	56.8	136	128	0	33	32
2015	7	1	15	14	8	0.666	-0.115	3.934	0.01	0.007	0	44.3	40.9	62.4	137	128	0	34	33
2015	7	1	15	24	8	0.692	-0.138	3.934	0.013	0.01	0	44.3	41.3	62.8	137	128	0	34	32
2015	7	1	15	34	8	0.676	-0.135	3.934	0.01	0.007	0	43.9	40.9	63.2	136	127	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	1	15	44	8	0.669	-0.138	3.934	0.01	0.007	0	44.7	40.9	53.8	137	128	0	33	33
2015	7	1	15	54	8	0.676	-0.131	3.93	0.013	0.01	0	45.2	41.7	52	138	129	0	33	32
2015	7	1	16	4	8	0.712	-0.112	3.93	0.013	0.01	0	44.3	40.9	52	137	128	0	34	33
2015	7	1	16	14	8	0.709	-0.115	3.934	0.01	0.007	0	44.3	40.9	51.2	137	128	0	34	33
2015	7	1	16	24	8	0.689	-0.121	3.93	0.01	0.007	0	44.7	41.7	46.9	138	129	0	34	32
2015	7	1	16	34	8	0.676	-0.121	3.934	0.01	0.007	0	43.9	40.9	53.3	136	128	0	34	33
2015	7	1	16	44	8	0.702	-0.112	3.934	0.016	0.013	0	43.9	40.4	51.6	136	127	0	34	33
2015	7	1	16	54	8	0.689	-0.098	3.934	0.013	0.01	0	44.3	41.3	53.3	137	128	0	34	32
2015	7	1	17	4	8	0.679	-0.135	3.93	0.01	0.007	0	44.3	40.9	52.5	136	127	0	33	32
2015	7	1	17	14	8	0.676	-0.118	3.93	0.013	0.01	0	44.3	40.9	54.6	136	127	0	33	32
2015	7	1	17	24	8	0.689	-0.085	3.934	0.013	0.01	0	43.9	40.9	52.5	136	127	0	34	32
2015	7	1	17	34	8	0.682	-0.121	3.93	0.01	0.007	0	43.9	40.9	54.6	136	128	0	34	33
2015	7	1	17	44	8	0.705	-0.092	3.934	0.01	0.007	0	44.3	40.9	63.6	136	127	0	33	32
2015	7	1	17	54	8	0.699	-0.108	3.93	0.01	0.007	0	43.9	40.4	53.8	136	127	0	34	33
2015	7	1	18	4	8	0.692	-0.105	3.934	0.013	0.01	0	43.9	40.4	64.1	136	127	0	34	33
2015	7	1	18	14	8	0.676	-0.066	3.934	0.013	0.01	0	44.3	41.7	59.8	137	129	0	34	32
2015	7	1	18	24	8	0.689	-0.125	3.934	0.016	0.013	0	44.3	40.9	67.9	136	128	0	33	33
2015	7	1	18	34	8	0.692	-0.125	3.934	0.013	0.01	0	43.9	40.4	67.9	136	127	0	34	33
2015	7	1	18	44	8	0.719	-0.105	3.934	0.01	0.007	0	44.3	40.9	67.1	136	127	0	33	32
2015	7	1	18	54	8	0.719	-0.118	3.934	0.01	0.007	0	44.3	40.9	69.2	137	128	0	34	33
2015	7	1	19	4	8	0.679	-0.121	3.934	0.01	0.007	0	43.9	40.4	64.9	135	127	0	33	33
2015	7	1	19	14	8	0.692	-0.118	3.934	0.01	0.007	0	44.7	41.3	66.2	137	128	0	33	32
2015	7	1	19	24	8	0.689	-0.098	3.934	0.013	0.01	0	45.6	42.6	58.5	140	131	0	34	32
2015	7	1	19	34	8	0.692	-0.092	3.937	0.013	0.01	0	48.6	45.2	68.8	146	137	0	33	32
2015	7	1	19	44	8	0.692	-0.052	3.937	0.01	0.007	0	46.9	43.4	67.5	143	134	0	34	33
2015	7	1	19	54	8	0.676	-0.108	3.937	0.016	0.013	0	46	42.1	68.4	140	131	0	33	33
2015	7	1	20	4	8	0.656	-0.075	3.937	0.01	0.007	0	46	42.6	69.2	140	131	0	33	32
2015	7	1	20	14	8	0.676	-0.112	3.937	0.01	0.007	0	45.6	42.6	69.2	140	131	0	34	32
2015	7	1	20	24	8	0.623	-0.069	3.937	0.01	0.007	0	46.4	43	70.5	141	132	0	33	32
2015	7	1	20	34	8	0.663	-0.079	3.937	0.013	0.01	0	46.4	43	69.7	142	133	0	34	33
2015	7	1	20	44	8	0.673	-0.059	3.937	0.01	0.007	0	46.4	43.4	68.8	142	134	0	34	33
2015	7	1	20	54	8	0.699	-0.075	3.94	0.016	0.013	0	46.9	43.4	67.9	142	133	0	33	32
2015	7	1	21	4	8	0.676	-0.069	3.94	0.013	0.01	0	47.3	44.7	67.1	144	136	0	34	32
2015	7	1	21	14	8	0.686	-0.072	3.94	0.01	0.007	0	46.9	43.4	70.1	143	133	0	34	32
2015	7	1	21	24	8	0.669	-0.069	3.94	0.013	0.01	0	46.4	43.4	70.5	142	134	0	34	33
2015	7	1	21	34	8	0.699	-0.092	3.94	0.013	0.01	0	46.9	43.9	69.7	143	135	0	34	33
2015	7	1	21	44	8	0.659	-0.089	3.94	0.01	0.007	0	46.4	43.4	68.8	142	133	0	34	32
2015	7	1	21	54	8	0.682	-0.108	3.94	0.01	0.007	0	46.9	43.9	70.5	143	134	0	34	32
2015	7	1	22	4	8	0.692	-0.089	3.944	0.01	0.007	0	47.7	43.9	67.9	144	135	0	33	33
2015	7	1	22	14	8	0.679	-0.085	3.944	0.016	0.013	0	46.9	43.9	71.4	143	134	0	34	32
2015	7	1	22	24	8	0.673	-0.089	3.944	0.01	0.007	0	47.3	43.9	68.4	144	135	0	34	33
2015	7	1	22	34	8	0.705	-0.069	3.944	0.016	0.013	0	47.3	44.3	71.8	144	135	0	34	32
2015	7	1	22	44	8	0.676	-0.072	3.944	0.016	0.013	0	47.7	45.2	71	145	137	0	34	32
2015	7	1	22	54	8	0.696	-0.075	3.944	0.01	0.007	0	47.3	43.9	69.7	144	135	0	34	33
2015	7	1	23	4	8	0.686	-0.062	3.944	0.01	0.007	0	47.7	44.3	71.4	144	136	0	33	33
2015	7	1	23	14	8	0.653	-0.089	3.944	0.013	0.01	0	48.6	45.6	71	147	138	0	34	32
2015	7	1	23	24	8	0.696	-0.121	3.944	0.01	0.007	0	47.3	44.3	70.5	144	135	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	1	23	34	8	0.673	-0.082	3.944	0.01	0.007	0	47.3	44.3	70.5	144	136	0	34	33
2015	7	1	23	44	8	0.686	-0.069	3.947	0.016	0.013	0	47.7	44.7	68.8	145	136	0	34	32
2015	7	1	23	54	8	0.686	-0.085	3.947	0.01	0.007	0	48.6	45.2	70.1	146	137	0	33	32
2015	7	2	0	4	8	0.705	-0.075	3.947	0.01	0.007	0	48.2	45.2	68.8	146	138	0	34	33
2015	7	2	0	14	8	0.686	-0.069	3.947	0.01	0.007	0	47.7	44.7	70.1	144	136	0	33	32
2015	7	2	0	24	8	0.669	-0.079	3.947	0.016	0.013	0	47.7	44.7	63.6	145	136	0	34	32
2015	7	2	0	34	8	0.689	-0.069	3.947	0.016	0.013	0	48.6	45.2	66.2	147	138	0	34	33
2015	7	2	0	44	8	0.686	-0.102	3.947	0.01	0.007	0	48.6	44.7	66.7	146	137	0	33	33
2015	7	2	0	54	8	0.653	-0.062	3.95	0.01	0.007	0	48.2	45.2	55.9	146	137	0	34	32
2015	7	2	1	4	8	0.646	-0.062	3.947	0.01	0.007	0	48.6	44.7	61.9	146	137	0	33	33
2015	7	2	1	14	8	0.686	-0.085	3.95	0.016	0.016	0	48.6	44.7	54.6	146	137	0	33	33
2015	7	2	1	24	8	0.673	-0.066	3.95	0.013	0.01	0	48.6	45.2	60.2	146	138	0	33	33
2015	7	2	1	34	8	0.676	-0.095	3.947	0.01	0.007	0	48.2	45.2	67.5	146	137	0	34	32
2015	7	2	1	44	8	0.682	-0.052	3.95	0.01	0.007	0	48.6	45.6	55	147	138	0	34	32
2015	7	2	1	54	8	0.659	-0.066	3.95	0.013	0.01	0	48.6	45.2	61.1	147	138	0	34	33
2015	7	2	2	4	8	0.659	-0.056	3.95	0.01	0.007	0	50.3	46.9	60.2	150	141	0	33	32
2015	7	2	2	14	8	0.696	-0.049	3.95	0.01	0.007	0	49.9	46.4	60.6	150	141	0	34	33
2015	7	2	2	24	8	0.689	-0.092	3.95	0.01	0.007	0	49	46.4	65.4	149	140	0	35	32
2015	7	2	2	34	8	0.686	-0.079	3.95	0.016	0.013	0	48.6	45.6	67.1	147	138	0	34	32
2015	7	2	2	44	8	0.679	-0.066	3.953	0.013	0.01	0	48.6	46	52	147	139	0	34	32
2015	7	2	2	54	8	0.682	-0.098	3.953	0.01	0.007	0	49	45.6	62.8	148	139	0	34	33
2015	7	2	3	4	8	0.669	-0.085	3.953	0.01	0.007	0	49	46	63.6	148	139	0	34	32
2015	7	2	3	14	8	0.646	-0.079	3.953	0.01	0.007	0	49.5	46	63.2	148	140	0	33	33
2015	7	2	3	24	8	0.673	-0.036	3.953	0.01	0.007	0	49	46	66.2	148	139	0	34	32
2015	7	2	3	34	8	0.663	-0.056	3.953	0.01	0.007	0	48.6	45.2	63.2	147	138	0	34	33
2015	7	2	3	44	8	0.712	-0.098	3.957	0.01	0.007	0	48.2	45.2	60.6	146	137	0	34	32
2015	7	2	3	54	8	0.666	-0.066	3.957	0.01	0.007	0	48.6	45.6	62.8	147	138	0	34	32
2015	7	2	4	4	8	0.682	-0.121	3.957	0.013	0.01	0	48.6	45.2	61.5	146	137	0	33	32
2015	7	2	4	14	8	0.715	-0.059	3.957	0.013	0.01	0	48.2	45.2	62.4	146	138	0	34	33
2015	7	2	4	24	8	0.682	-0.125	3.96	0.013	0.01	0	47.3	44.3	55	144	135	0	34	32
2015	7	2	4	34	8	0.679	-0.085	3.96	0.01	0.007	0	48.2	45.2	60.2	146	138	0	34	33
2015	7	2	4	44	8	0.712	-0.105	3.96	0.013	0.01	0	49	45.6	62.4	147	138	0	33	32
2015	7	2	4	54	8	0.712	-0.069	3.96	0.013	0.01	0	48.6	45.2	63.6	147	138	0	34	33
2015	7	2	5	4	8	0.699	-0.059	3.96	0.013	0.01	0	49	45.6	63.2	148	139	0	34	33
2015	7	2	5	14	8	0.673	-0.066	3.963	0.01	0.007	0	48.2	44.7	64.9	145	136	0	33	32
2015	7	2	5	24	8	0.689	-0.075	3.963	0.01	0.007	0	47.7	43.9	64.5	144	135	0	33	33
2015	7	2	5	34	8	0.676	-0.085	3.967	0.013	0.01	0	46.9	43.9	64.1	143	134	0	34	32
2015	7	2	5	44	8	0.689	-0.085	3.97	0.01	0.007	0	46.9	43.4	65.8	142	134	0	33	33
2015	7	2	5	54	8	0.679	-0.095	3.97	0.013	0.01	0	46.9	43.4	64.1	143	134	0	34	33
2015	7	2	6	4	8	0.676	-0.115	3.973	0.01	0.007	0	46.9	44.3	66.7	143	135	0	34	32
2015	7	2	6	14	8	0.696	-0.095	3.973	0.013	0.01	0	46.4	43	67.9	141	132	0	33	32
2015	7	2	6	24	8	0.686	-0.085	3.973	0.01	0.007	0	46.4	43.4	66.7	141	133	0	33	32
2015	7	2	6	34	8	0.676	-0.052	3.973	0.013	0.01	0	46.4	42.6	67.1	141	132	0	33	33
2015	7	2	6	44	8	0.689	-0.105	3.973	0.013	0.01	0	46.9	43.9	60.2	143	134	0	34	32
2015	7	2	6	54	8	0.686	-0.079	3.976	0.01	0.007	0	46.4	42.6	67.5	141	132	0	33	33
2015	7	2	7	4	8	0.696	-0.036	3.976	0.01	0.007	0	46	43	66.7	141	132	0	34	32
2015	7	2	7	14	8	0.705	-0.085	3.976	0.013	0.01	0	46	42.1	66.2	140	131	0	33	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	2	7	24	8	0.712	-0.075	3.976	0.01	0.007	0	45.2	42.6	69.2	139	131	0	34	32
2015	7	2	7	34	8	0.705	-0.082	3.976	0.016	0.013	0	46	42.1	69.2	140	131	0	33	33
2015	7	2	7	44	8	0.686	-0.072	3.976	0.01	0.007	0	45.2	42.1	70.1	139	131	0	34	33
2015	7	2	7	54	8	0.712	-0.075	3.976	0.01	0.007	0	45.6	42.6	70.1	140	131	0	34	32
2015	7	2	8	4	8	0.676	-0.098	3.976	0.01	0.007	0	46	42.6	69.2	140	131	0	33	32
2015	7	2	8	14	8	0.699	-0.098	3.98	0.013	0.01	0	44.7	41.7	68.8	138	130	0	34	33
2015	7	2	8	24	8	0.692	-0.072	3.98	0.013	0.01	0	45.2	42.1	69.7	139	131	0	34	33
2015	7	2	8	34	8	0.692	-0.075	3.98	0.01	0.007	0	46	43	70.1	140	132	0	33	32
2015	7	2	8	44	8	0.663	-0.102	3.98	0.01	0.007	0	45.6	43	70.5	140	133	0	34	33
2015	7	2	8	54	8	0.682	-0.082	3.98	0.01	0.007	0	46	43.4	71	141	133	0	34	32
2015	7	2	9	4	8	0.702	-0.095	3.98	0.01	0.007	0	45.6	43	70.5	140	132	0	34	32
2015	7	2	9	14	8	0.699	-0.092	3.98	0.01	0.007	0	45.6	42.1	71.4	140	131	0	34	33
2015	7	2	9	24	8	0.682	-0.082	3.98	0.013	0.01	0	45.6	42.6	71	139	131	0	33	32
2015	7	2	9	34	8	0.682	-0.125	3.98	0.013	0.01	0	45.6	43	67.9	140	132	0	34	32
2015	7	2	9	44	8	0.692	-0.085	3.983	0.013	0.01	0	45.6	42.1	71.4	139	131	0	33	33
2015	7	2	9	54	8	0.696	-0.092	3.983	0.01	0.007	0	45.6	42.6	71.4	140	131	0	34	32
2015	7	2	10	4	8	0.689	-0.098	3.983	0.01	0.007	0	44.7	41.7	72.2	138	130	0	34	33
2015	7	2	10	14	8	0.656	-0.082	3.983	0.01	0.007	0	46	43	72.2	141	132	0	34	32
2015	7	2	10	24	8	0.682	-0.125	3.98	0.013	0.01	0	44.7	41.7	62.4	138	129	0	34	32
2015	7	2	10	34	8	0.705	-0.108	3.983	0.01	0.007	0	44.3	41.3	71.8	137	128	0	34	32
2015	7	2	10	44	8	0.705	-0.102	3.983	0.013	0.01	0	44.3	41.3	72.7	137	129	0	34	33
2015	7	2	10	54	8	0.741	-0.085	3.983	0.013	0.01	0	45.2	41.3	72.2	138	129	0	33	33
2015	7	2	11	4	8	0.719	-0.105	3.983	0.01	0.007	0	44.7	41.3	72.7	137	129	0	33	33
2015	7	2	11	14	8	0.712	-0.115	3.983	0.01	0.007	0	44.3	41.3	72.7	137	129	0	34	33
2015	7	2	11	24	8	0.689	-0.098	3.983	0.013	0.01	0	45.2	41.7	73.1	138	129	0	33	32
2015	7	2	11	34	8	0.686	-0.105	3.983	0.01	0.007	0	44.3	41.3	72.2	137	129	0	34	33
2015	7	2	11	44	8	0.673	-0.069	3.983	0.01	0.007	0	44.3	41.7	71.4	137	129	0	34	32
2015	7	2	11	54	8	0.673	-0.105	3.983	0.01	0.007	0	44.7	42.1	72.7	138	130	0	34	32
2015	7	2	12	4	8	0.709	-0.105	3.983	0.016	0.013	0	45.2	42.1	72.2	137	130	0	32	32
2015	7	2	12	14	8	0.702	-0.089	3.983	0.016	0.013	0	44.3	41.7	72.7	137	129	0	34	32
2015	7	2	12	24	8	0.682	-0.092	3.983	0.013	0.01	0	44.7	41.3	72.7	137	129	0	33	33
2015	7	2	12	34	8	0.696	-0.092	3.983	0.01	0.007	0	44.7	41.7	72.2	138	130	0	34	33
2015	7	2	12	44	8	0.696	-0.118	3.986	0.01	0.007	0	43.9	41.3	72.7	136	128	0	34	32
2015	7	2	12	54	8	0.682	-0.069	3.986	0.01	0.007	0	44.7	41.3	72.2	137	129	0	33	33
2015	7	2	13	4	8	0.686	-0.102	3.986	0.01	0.007	0	43.4	40.9	72.7	135	128	0	34	33
2015	7	2	13	14	8	0.705	-0.092	3.986	0.01	0.007	0	43.4	40.9	70.5	135	127	0	34	32
2015	7	2	13	24	8	0.679	-0.102	3.986	0.01	0.007	0	44.3	41.3	71.4	136	128	0	33	32
2015	7	2	13	34	8	0.679	-0.062	3.986	0.013	0.01	0	43.9	40.9	72.2	136	128	0	34	33
2015	7	2	13	44	8	0.702	-0.079	3.983	0.01	0.007	0	44.3	41.3	71.8	137	128	0	34	32
2015	7	2	13	54	8	0.715	-0.112	3.983	0.01	0.007	0	44.3	40.9	72.2	136	128	0	33	33
2015	7	2	14	4	8	0.702	-0.089	3.986	0.01	0.007	0	44.3	40.9	72.2	136	127	0	33	32
2015	7	2	14	14	8	0.643	-0.079	3.986	0.01	0.007	0	43.9	40.9	71.8	135	127	0	33	32
2015	7	2	14	24	8	0.705	-0.115	3.983	0.01	0.007	0	44.3	41.3	49.9	137	129	0	34	33
2015	7	2	14	34	8	0.712	-0.121	3.98	0.01	0.007	0	49.5	46.9	37.4	149	141	0	34	32
2015	7	2	14	44	8	0.689	-0.085	3.98	0.013	0.01	0	50.7	47.3	46.9	151	143	0	33	33
2015	7	2	14	54	8	0.732	-0.131	3.983	0.01	0.007	0	44.7	42.6	49.9	138	131	0	34	32
2015	7	2	15	4	8	0.689	-0.125	3.986	0.01	0.007	0	43	39.6	58.5	134	125	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	2	15	14	8	0.666	-0.131	3.983	0.013	0.01	0	42.1	40	59.8	132	125	0	34	32
2015	7	2	15	24	8	0.666	-0.121	3.986	0.01	0.007	0	42.6	39.6	71.8	133	124	0	34	32
2015	7	2	15	34	8	0.715	-0.112	3.986	0.013	0.01	0	42.6	39.6	71	133	125	0	34	33
2015	7	2	15	44	8	0.699	-0.098	3.986	0.01	0.007	0	42.1	39.6	65.8	132	124	0	34	32
2015	7	2	15	54	8	0.705	-0.082	3.983	0.013	0.01	0	43.9	41.3	50.7	136	128	0	34	32
2015	7	2	16	4	8	0.699	-0.121	3.983	0.01	0.007	0	42.1	39.6	61.9	132	125	0	34	33
2015	7	2	16	14	8	0.699	-0.092	3.986	0.013	0.01	0	42.6	40	72.2	133	125	0	34	32
2015	7	2	16	24	8	0.709	-0.105	3.986	0.01	0.007	0	42.1	39.1	68.8	132	124	0	34	33
2015	7	2	16	34	8	0.732	-0.118	3.986	0.01	0.007	0	42.6	39.6	73.1	132	124	0	33	32
2015	7	2	16	44	8	0.709	-0.069	3.986	0.013	0.01	0	42.6	40	69.7	133	125	0	34	32
2015	7	2	16	54	8	0.712	-0.138	3.983	0.01	0.007	0	43	40	58	133	125	0	33	32
2015	7	2	17	4	8	0.719	-0.121	3.983	0.01	0.007	0	43.4	39.6	52.5	135	125	0	34	33
2015	7	2	17	14	8	0.699	-0.125	3.986	0.013	0.01	0	41.7	39.1	72.2	131	124	0	34	33
2015	7	2	17	24	8	0.719	-0.105	3.986	0.016	0.016	0	42.6	39.6	72.7	132	124	0	33	32
2015	7	2	17	34	8	0.699	-0.128	3.986	0.016	0.013	0	41.7	39.6	71.4	131	123	0	34	31
2015	7	2	17	44	8	0.728	-0.098	3.986	0.01	0.007	0	42.6	40	72.7	132	125	0	33	32
2015	7	2	17	54	8	0.673	-0.121	3.986	0.01	0.007	0	42.6	39.6	55.9	133	125	0	34	33
2015	7	2	18	4	8	0.673	-0.138	3.986	0.01	0.007	0	43.4	40	47.3	134	126	0	33	33
2015	7	2	18	14	8	0.705	-0.115	3.986	0.01	0.007	0	42.1	40	52	132	125	0	34	32
2015	7	2	18	24	8	0.719	-0.112	3.986	0.01	0.007	0	42.6	39.6	53.8	132	124	0	33	32
2015	7	2	18	34	8	0.715	-0.148	3.986	0.013	0.01	0	42.6	39.6	53.8	133	125	0	34	33
2015	7	2	18	44	8	0.666	-0.115	3.986	0.01	0.007	0	43	40	49.5	133	125	0	33	32
2015	7	2	18	54	8	0.712	-0.075	3.986	0.013	0.01	0	42.6	39.6	54.6	132	124	0	33	32
2015	7	2	19	4	8	0.715	-0.092	3.986	0.016	0.013	0	42.6	40	57.6	133	125	0	34	32
2015	7	2	19	14	8	0.689	-0.121	3.986	0.01	0.007	0	42.1	39.6	58.5	132	124	0	34	32
2015	7	2	19	24	8	0.712	-0.121	3.986	0.013	0.01	0	43	40	59.3	133	125	0	33	32
2015	7	2	19	34	8	0.689	-0.082	3.986	0.013	0.01	0	42.6	40	62.8	133	125	0	34	32
2015	7	2	19	44	8	0.715	-0.095	3.986	0.01	0.007	0	43	39.6	71.8	133	125	0	33	33
2015	7	2	19	54	8	0.705	-0.069	3.986	0.01	0.007	0	43.4	40.4	72.2	134	126	0	33	32
2015	7	2	20	4	8	0.715	-0.108	3.99	0.01	0.007	0	46	42.6	71.4	140	132	0	33	33
2015	7	2	20	14	8	0.689	-0.108	3.99	0.013	0.01	0	44.7	40.9	72.2	137	128	0	33	33
2015	7	2	20	24	8	0.686	-0.069	3.99	0.01	0.007	0	44.3	41.3	72.2	136	128	0	33	32
2015	7	2	20	34	8	0.699	-0.089	3.99	0.013	0.01	0	43.9	41.3	71.8	136	128	0	34	32
2015	7	2	20	44	8	0.666	-0.056	3.99	0.01	0.007	0	45.2	42.1	71.4	138	130	0	33	32
2015	7	2	20	54	8	0.669	-0.062	3.99	0.01	0.007	0	46	43	69.7	141	133	0	34	33
2015	7	2	21	4	8	0.715	-0.085	3.99	0.01	0.007	0	46.4	43.4	67.9	141	133	0	33	32
2015	7	2	21	14	8	0.676	-0.062	3.99	0.013	0.01	0	45.6	42.6	68.8	139	131	0	33	32
2015	7	2	21	24	8	0.699	-0.085	3.99	0.013	0.01	0	44.7	42.1	69.2	138	130	0	34	32
2015	7	2	21	34	8	0.715	-0.079	3.993	0.01	0.007	0	45.2	41.7	69.7	138	129	0	33	32
2015	7	2	21	44	8	0.696	-0.105	3.993	0.016	0.013	0	44.3	41.7	71	137	129	0	34	32
2015	7	2	21	54	8	0.705	-0.069	3.993	0.013	0.01	0	44.7	41.7	70.5	138	130	0	34	33
2015	7	2	22	4	8	0.682	-0.059	3.993	0.01	0.007	0	44.3	41.7	70.1	137	129	0	34	32
2015	7	2	22	14	8	0.692	-0.095	3.993	0.01	0.007	0	44.7	41.7	70.1	137	129	0	33	32
2015	7	2	22	24	8	0.673	-0.069	3.993	0.01	0.007	0	44.7	41.7	71	137	129	0	33	32
2015	7	2	22	34	8	0.709	-0.072	3.993	0.01	0.007	0	44.3	41.3	71	137	129	0	34	33
2015	7	2	22	44	8	0.646	-0.066	3.993	0.01	0.007	0	44.7	42.1	70.5	138	130	0	34	32
2015	7	2	22	54	8	0.712	-0.069	3.993	0.01	0.007	0	45.2	41.7	70.1	138	130	0	33	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	2	23	4	8	0.699	-0.082	3.996	0.01	0.007	0	45.2	42.1	70.1	138	130	0	33	32
2015	7	2	23	14	8	0.696	-0.115	3.996	0.01	0.007	0	44.7	41.7	70.5	137	129	0	33	32
2015	7	2	23	24	8	0.699	-0.082	3.996	0.016	0.013	0	45.2	42.1	69.7	138	130	0	33	32
2015	7	2	23	34	8	0.699	-0.108	3.996	0.013	0.01	0	44.3	40.9	70.1	137	128	0	34	33
2015	7	2	23	44	8	0.696	-0.075	3.996	0.01	0.007	0	44.3	41.3	69.7	136	128	0	33	32
2015	7	2	23	54	8	0.686	-0.095	3.996	0.013	0.01	0	43.9	41.3	69.7	136	128	0	34	32
2015	7	3	0	4	8	0.732	-0.089	3.996	0.01	0.007	0	44.3	41.3	69.2	136	128	0	33	32
2015	7	3	0	14	8	0.673	-0.108	3.996	0.01	0.007	0	44.7	41.3	69.7	137	129	0	33	33
2015	7	3	0	24	8	0.699	-0.085	3.999	0.013	0.01	0	44.7	41.7	69.2	137	129	0	33	32
2015	7	3	0	34	8	0.686	-0.095	3.999	0.016	0.013	0	44.7	42.1	69.2	138	130	0	34	32
2015	7	3	0	44	8	0.676	-0.046	3.999	0.01	0.007	0	45.2	42.1	69.2	138	130	0	33	32
2015	7	3	0	54	8	0.699	-0.089	3.999	0.016	0.013	0	45.2	42.1	67.9	139	131	0	34	33
2015	7	3	1	4	8	0.699	-0.092	3.999	0.013	0.01	0	45.6	42.1	67.5	139	130	0	33	32
2015	7	3	1	14	8	0.702	-0.079	3.999	0.016	0.013	0	44.7	40.9	66.7	137	128	0	33	33
2015	7	3	1	24	8	0.679	-0.082	3.999	0.01	0.007	0	45.2	41.7	68.8	138	129	0	33	32
2015	7	3	1	34	8	0.699	-0.092	3.999	0.013	0.01	0	46	43.4	66.7	141	133	0	34	32
2015	7	3	1	44	8	0.709	-0.102	4.003	0.013	0.01	0	46	42.6	67.9	140	131	0	33	32
2015	7	3	1	54	8	0.692	-0.039	4.003	0.013	0.01	0	45.6	42.6	67.5	140	132	0	34	33
2015	7	3	2	4	8	0.686	-0.089	4.012	0.01	0.007	0	46	42.6	52.9	140	131	0	33	32
2015	7	3	2	14	8	0.705	-0.066	4.009	0.01	0.007	0	47.3	44.3	65.4	143	135	0	33	32
2015	7	3	2	24	8	0.689	-0.092	4.009	0.016	0.013	0	46.4	43.4	65.8	141	133	0	33	32
2015	7	3	2	34	8	0.692	-0.046	4.012	0.01	0.007	0	45.6	42.6	66.2	139	131	0	33	32
2015	7	3	2	44	8	0.715	-0.072	4.012	0.016	0.013	0	45.2	42.6	65.8	139	131	0	34	32
2015	7	3	2	54	8	0.696	-0.056	4.016	0.01	0.007	0	45.6	42.6	67.5	139	131	0	33	32
2015	7	3	3	4	8	0.715	-0.059	4.016	0.01	0.007	0	45.2	42.1	67.1	138	130	0	33	32
2015	7	3	3	14	8	0.715	-0.095	4.016	0.01	0.007	0	45.2	42.1	63.6	138	130	0	33	32
2015	7	3	3	24	8	0.696	-0.092	4.016	0.013	0.01	0	44.7	42.1	68.8	138	130	0	34	32
2015	7	3	3	34	8	0.682	-0.098	4.016	0.013	0.01	0	45.6	41.7	68.8	139	130	0	33	33
2015	7	3	3	44	8	0.689	-0.085	4.016	0.013	0.01	0	44.7	42.1	69.2	138	130	0	34	32
2015	7	3	3	54	8	0.719	-0.102	4.016	0.013	0.01	0	44.7	41.7	68.4	137	129	0	33	32
2015	7	3	4	4	8	0.705	-0.059	4.019	0.01	0.007	0	45.2	42.1	68.8	139	130	0	34	32
2015	7	3	4	14	8	0.696	-0.098	4.019	0.01	0.007	0	45.2	41.7	69.7	138	129	0	33	32
2015	7	3	4	24	8	0.715	-0.092	4.019	0.013	0.01	0	44.7	41.3	69.2	137	128	0	33	32
2015	7	3	4	34	8	0.696	-0.095	4.019	0.01	0.007	0	44.7	41.7	64.9	138	130	0	34	33
2015	7	3	4	44	8	0.699	-0.069	4.019	0.013	0.01	0	45.2	42.1	70.1	139	130	0	34	32
2015	7	3	4	54	8	0.709	-0.062	4.019	0.01	0.007	0	45.2	41.7	70.5	138	129	0	33	32
2015	7	3	5	4	8	0.735	-0.079	4.019	0.01	0.007	0	44.3	41.7	70.5	137	129	0	34	32
2015	7	3	5	14	8	0.715	-0.075	4.022	0.01	0.007	0	44.7	41.3	71	137	128	0	33	32
2015	7	3	5	24	8	0.692	-0.069	4.022	0.01	0.007	0	45.2	41.3	71	138	129	0	33	33
2015	7	3	5	34	8	0.712	-0.052	4.022	0.01	0.007	0	44.7	41.3	71.8	137	129	0	33	33
2015	7	3	5	44	8	0.696	-0.079	4.022	0.013	0.01	0	45.2	41.3	71.4	137	129	0	32	33
2015	7	3	5	54	8	0.679	-0.089	4.022	0.013	0.01	0	44.7	41.3	71.4	137	128	0	33	32
2015	7	3	6	4	8	0.696	-0.062	4.022	0.01	0.007	0	43.9	40.9	70.1	136	128	0	34	33
2015	7	3	6	14	8	0.705	-0.075	4.022	0.01	0.007	0	44.7	41.3	72.2	137	128	0	33	32
2015	7	3	6	24	8	0.719	-0.062	4.022	0.016	0.016	0	43.9	40.9	71.4	135	127	0	33	32
2015	7	3	6	34	8	0.712	-0.059	4.022	0.013	0.01	0	43.4	40.9	72.7	135	127	0	34	32
2015	7	3	6	44	8	0.696	-0.105	4.022	0.016	0.013	0	43.9	40.9	71.8	135	127	0	33	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	3	6	54	8	0.702	-0.095	4.022	0.013	0.01	0	43.4	40	71	134	126	0	33	33
2015	7	3	7	4	8	0.65	-0.059	4.022	0.01	0.007	0	43.4	41.3	70.5	135	127	0	34	31
2015	7	3	7	14	8	0.689	-0.066	4.026	0.01	0.007	0	43.4	40.4	70.5	135	126	0	34	32
2015	7	3	7	24	8	0.696	-0.069	4.026	0.01	0.007	0	43	40.4	71.8	134	126	0	34	32
2015	7	3	7	34	8	0.689	-0.085	4.026	0.01	0.007	0	43.4	40.9	70.5	135	127	0	34	32
2015	7	3	7	44	8	0.686	-0.085	4.026	0.013	0.01	0	43.9	40.4	70.5	135	126	0	33	32
2015	7	3	7	54	8	0.705	-0.085	4.026	0.013	0.01	0	43.9	40.9	71.4	135	127	0	33	32
2015	7	3	8	4	8	0.696	-0.089	4.026	0.013	0.01	0	43.4	40.9	71.4	135	127	0	34	32
2015	7	3	8	14	8	0.689	-0.082	4.026	0.01	0.007	0	43.4	40.4	72.2	135	127	0	34	33
2015	7	3	8	24	8	0.705	-0.066	4.026	0.01	0.007	0	43.4	40	71.4	134	126	0	33	33
2015	7	3	8	34	8	0.709	-0.121	4.026	0.013	0.01	0	43.4	40.4	71.8	134	126	0	33	32
2015	7	3	8	44	8	0.728	-0.102	4.026	0.01	0.007	0	43	40	71.8	134	126	0	34	33
2015	7	3	8	54	8	0.712	-0.092	4.026	0.01	0.007	0	43	40.4	70.5	134	126	0	34	32
2015	7	3	9	4	8	0.686	-0.072	4.026	0.013	0.01	0	43	40.4	71.4	134	126	0	34	32
2015	7	3	9	14	8	0.696	-0.066	4.026	0.01	0.007	0	44.3	40.4	71	136	127	0	33	33
2015	7	3	9	24	8	0.692	-0.121	4.026	0.013	0.01	0	43.4	39.6	71.4	135	126	0	34	34
2015	7	3	9	34	8	0.712	-0.082	4.026	0.01	0.007	0	43	40	71	134	126	0	34	33
2015	7	3	9	44	8	0.741	-0.085	4.026	0.01	0.007	0	43.9	40.4	71	135	126	0	33	32
2015	7	3	9	54	8	0.702	-0.079	4.026	0.01	0.007	0	43.9	40.9	71.4	135	127	0	33	32
2015	7	3	10	4	8	0.715	-0.115	4.029	0.01	0.007	0	43.9	40.9	71.4	135	127	0	33	32
2015	7	3	10	14	8	0.709	-0.102	4.026	0.01	0.007	0	43.4	40.4	71	134	127	0	33	33
2015	7	3	10	24	8	0.728	-0.095	4.029	0.013	0.01	0	43	40	71.4	134	126	0	34	33
2015	7	3	10	34	8	0.702	-0.095	4.029	0.01	0.007	0	42.6	40	71.8	133	125	0	34	32
2015	7	3	10	44	8	0.696	-0.108	4.029	0.013	0.01	0	42.6	39.6	67.9	133	125	0	34	33
2015	7	3	10	54	8	0.696	-0.138	4.026	0.01	0.007	0	42.1	39.1	71.8	132	124	0	34	33
2015	7	3	11	4	8	0.676	-0.105	4.026	0.013	0.01	0	42.6	40.4	71	133	125	0	34	31
2015	7	3	11	14	8	0.702	-0.154	4.026	0.01	0.007	0	41.7	38.7	68.4	131	123	0	34	33
2015	7	3	11	24	8	0.709	-0.095	4.026	0.013	0.01	0	43	39.1	58.5	133	124	0	33	33
2015	7	3	11	34	8	0.712	-0.138	4.029	0.01	0.007	0	41.3	38.3	42.1	130	122	0	34	33
2015	7	3	11	44	8	0.669	-0.157	4.026	0.016	0.013	0	45.2	40	39.6	138	125	0	33	32
2015	7	3	11	54	8	0.738	-0.148	4.026	0.01	0.007	0	42.6	39.6	49.9	133	124	0	34	32
2015	7	3	12	4	8	0.722	-0.118	4.026	0.016	0.013	0	41.7	39.1	57.2	131	123	0	34	32
2015	7	3	12	14	8	0.696	-0.131	4.026	0.016	0.013	0	42.1	39.1	68.4	131	123	0	33	32
2015	7	3	12	24	8	0.679	-0.102	4.029	0.01	0.007	0	43.4	39.6	51.2	134	125	0	33	33
2015	7	3	12	34	8	0.712	-0.174	4.026	0.01	0.007	0	42.1	39.6	53.3	132	124	0	34	32
2015	7	3	12	44	8	0.669	-0.151	4.029	0.01	0.007	0	42.1	39.1	45.6	132	123	0	34	32
2015	7	3	12	54	8	0.732	-0.105	4.026	0.013	0.01	0	42.1	39.1	58.5	132	123	0	34	32
2015	7	3	13	4	8	0.696	-0.125	4.026	0.01	0.007	0	42.6	39.6	59.3	132	124	0	33	32
2015	7	3	13	14	8	0.728	-0.154	4.022	0.013	0.01	0	43.4	39.6	46.4	135	124	0	34	32
2015	7	3	13	24	8	0.702	-0.128	4.022	0.01	0.007	0	47.3	44.3	46.4	144	135	0	34	32
2015	7	3	13	34	8	0.679	-0.131	4.026	0.013	0.01	0	43.9	40.4	55.9	136	127	0	34	33
2015	7	3	13	44	8	0.758	-0.154	4.026	0.01	0.007	0	42.1	39.1	58.5	132	124	0	34	33
2015	7	3	13	54	8	0.748	-0.18	4.026	0.01	0.007	0	43.4	40	57.6	134	125	0	33	32
2015	7	3	14	4	8	0.699	-0.105	4.026	0.01	0.007	0	46.9	43.4	56.8	142	133	0	33	32
2015	7	3	14	14	8	0.758	-0.095	4.026	0.013	0.01	0	51.2	48.2	49.5	153	144	0	34	32
2015	7	3	14	24	8	0.689	-0.141	4.026	0.01	0.007	0	50.7	48.2	53.8	152	144	0	34	32
2015	7	3	14	34	8	0.689	-0.138	4.022	0.01	0.007	0	47.7	43.4	50.3	144	134	0	33	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	3	14	44	8	0.712	-0.105	4.026	0.013	0.01	0	48.6	45.6	50.3	147	138	0	34	32
2015	7	3	14	54	8	0.692	-0.184	4.022	0.013	0.01	0	47.3	43	43	143	132	0	33	32
2015	7	3	15	4	8	0.673	-0.075	4.026	0.01	0.007	0	52.5	48.2	40.9	156	145	0	34	33
2015	7	3	15	14	8	0.663	-0.128	4.022	0.013	0.01	0	49.5	46	52	149	138	0	34	31
2015	7	3	15	24	8	0.712	-0.115	4.019	0.01	0.007	0	50.7	45.6	49.9	151	138	0	33	32
2015	7	3	15	34	8	0.643	-0.125	4.019	0.01	0.007	0	46.9	43	44.7	143	132	0	34	32
2015	7	3	15	44	8	0.692	-0.102	4.026	0.01	0.007	0	52.5	49	43.9	156	146	0	34	32
2015	7	3	15	54	8	0.682	-0.138	4.022	0.01	0.007	0	48.6	45.2	39.1	148	137	0	35	32
2015	7	3	16	4	8	0.607	-0.135	4.022	0.013	0.01	0	49	43.9	42.6	148	134	0	34	32
2015	7	3	16	14	8	0.712	-0.115	4.019	0.01	0.007	0	46	42.1	40.9	141	130	0	34	32
2015	7	3	16	24	8	0.725	-0.085	4.022	0.016	0.013	0	53.8	49.5	41.3	158	148	0	33	33
2015	7	3	16	34	8	0.692	-0.118	4.026	0.01	0.007	0	44.7	40.9	50.3	138	127	0	34	32
2015	7	3	16	44	8	0.715	-0.148	4.026	0.01	0.007	0	44.3	40.9	49.9	137	127	0	34	32
2015	7	3	16	54	8	0.705	-0.121	4.026	0.01	0.007	0	44.3	40.4	49.5	137	127	0	34	33
2015	7	3	17	4	8	0.715	-0.085	4.026	0.01	0.007	0	43.9	40	47.7	135	126	0	33	33
2015	7	3	17	14	8	0.715	-0.092	4.029	0.013	0.01	0	43.9	40.9	50.7	135	127	0	33	32
2015	7	3	17	24	8	0.712	-0.118	4.022	0.013	0.01	0	44.3	40.4	49	136	126	0	33	32
2015	7	3	17	34	8	0.709	-0.102	4.026	0.01	0.007	0	45.2	41.7	50.7	138	130	0	33	33
2015	7	3	17	44	8	0.712	-0.085	4.029	0.01	0.007	0	46	43.4	53.3	141	133	0	34	32
2015	7	3	17	54	8	0.692	-0.079	4.029	0.01	0.007	0	43.9	40.4	52	135	126	0	33	32
2015	7	3	18	4	8	0.732	-0.128	4.026	0.01	0.007	0	43	40	58	133	125	0	33	32
2015	7	3	18	14	8	0.732	-0.118	4.026	0.013	0.01	0	42.6	39.1	61.1	132	124	0	33	33
2015	7	3	18	24	8	0.715	-0.112	4.026	0.013	0.01	0	43	40.4	60.6	134	126	0	34	32
2015	7	3	18	34	8	0.653	-0.056	4.026	0.01	0.007	0	43.9	40.4	58.5	135	126	0	33	32
2015	7	3	18	44	8	0.699	-0.121	4.026	0.016	0.013	0	43	40	55.5	134	126	0	34	33
2015	7	3	18	54	8	0.715	-0.112	4.029	0.013	0.01	0	43	39.6	56.3	133	125	0	33	33
2015	7	3	19	4	8	0.696	-0.069	4.029	0.01	0.007	0	42.6	40	58.9	133	125	0	34	32
2015	7	3	19	14	8	0.722	-0.108	4.029	0.01	0.007	0	43.4	40	63.6	134	125	0	33	32
2015	7	3	19	24	8	0.702	-0.082	4.029	0.01	0.007	0	43	40	54.6	134	125	0	34	32
2015	7	3	19	34	8	0.705	-0.085	4.029	0.013	0.01	0	42.6	39.6	65.8	133	124	0	34	32
2015	7	3	19	44	8	0.702	-0.052	4.029	0.013	0.01	0	43	40	71.8	133	125	0	33	32
2015	7	3	19	54	8	0.728	-0.075	4.029	0.01	0.007	0	44.7	41.7	71.8	137	129	0	33	32
2015	7	3	20	4	8	0.712	-0.098	4.029	0.01	0.007	0	45.6	42.1	71	139	130	0	33	32
2015	7	3	20	14	8	0.712	-0.069	4.029	0.013	0.01	0	43.9	40.9	68.4	136	127	0	34	32
2015	7	3	20	24	8	0.722	-0.092	4.029	0.01	0.007	0	43.9	40.9	68.4	135	126	0	33	31
2015	7	3	20	34	8	0.702	-0.089	4.029	0.01	0.007	0	43.9	40.9	63.6	136	127	0	34	32
2015	7	3	20	44	8	0.715	-0.072	4.029	0.01	0.007	0	43.9	40.9	71.4	136	127	0	34	32
2015	7	3	20	54	8	0.715	-0.069	4.029	0.016	0.013	0	44.3	41.3	70.1	136	128	0	33	32
2015	7	3	21	4	8	0.705	-0.075	4.029	0.01	0.007	0	44.7	41.3	70.5	137	128	0	33	32
2015	7	3	21	14	8	0.679	-0.089	4.029	0.016	0.013	0	44.3	40.4	71	136	127	0	33	33
2015	7	3	21	24	8	0.722	-0.082	4.032	0.01	0.007	0	43.9	40.9	70.5	136	127	0	34	32
2015	7	3	21	34	8	0.682	-0.062	4.032	0.01	0.007	0	44.3	40.9	69.7	136	127	0	33	32
2015	7	3	21	44	8	0.702	-0.082	4.032	0.01	0.007	0	44.3	40.9	70.5	136	127	0	33	32
2015	7	3	21	54	8	0.699	-0.095	4.032	0.013	0.01	0	43.9	40.4	71.4	135	126	0	33	32
2015	7	3	22	4	8	0.715	-0.069	4.032	0.016	0.013	0	44.3	40.9	70.1	137	128	0	34	33
2015	7	3	22	14	8	0.725	-0.112	4.032	0.01	0.007	0	44.3	40.9	71.4	136	127	0	33	32
2015	7	3	22	24	8	0.715	-0.062	4.032	0.016	0.013	0	43.4	40.4	71.8	135	126	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	3	22	34	8	0.702	-0.069	4.032	0.01	0.007	0	43.9	40	65.8	135	126	0	33	33
2015	7	3	22	44	8	0.679	-0.059	4.032	0.016	0.016	0	44.3	41.7	70.1	137	129	0	34	32
2015	7	3	22	54	8	0.686	-0.085	4.032	0.01	0.007	0	44.3	40.9	71.4	136	127	0	33	32
2015	7	3	23	4	8	0.712	-0.082	4.032	0.01	0.007	0	43.9	40.4	71.4	135	126	0	33	32
2015	7	3	23	14	8	0.676	-0.069	4.035	0.013	0.01	0	43.4	40	70.5	135	126	0	34	33
2015	7	3	23	24	8	0.712	-0.082	4.035	0.01	0.007	0	43.4	40.9	70.5	134	126	0	33	31
2015	7	3	23	34	8	0.692	-0.095	4.035	0.01	0.007	0	43	40.4	71	134	126	0	34	32
2015	7	3	23	44	8	0.722	-0.085	4.035	0.01	0.007	0	43.4	39.6	71	134	125	0	33	33
2015	7	3	23	54	8	0.699	-0.052	4.035	0.016	0.013	0	43.9	40.4	70.5	135	126	0	33	32
2015	7	4	0	4	8	0.709	-0.079	4.035	0.01	0.007	0	44.3	40.9	70.1	136	127	0	33	32
2015	7	4	0	14	8	0.699	-0.105	4.035	0.013	0.01	0	43.9	40.4	71	135	126	0	33	32
2015	7	4	0	24	8	0.735	-0.059	4.035	0.01	0.007	0	43.9	40.4	71	135	126	0	33	32
2015	7	4	0	34	8	0.712	-0.043	4.035	0.01	0.007	0	43.9	40	70.5	135	126	0	33	33
2015	7	4	0	44	8	0.719	-0.075	4.035	0.01	0.007	0	43.9	40.9	70.1	135	127	0	33	32
2015	7	4	0	54	8	0.696	-0.082	4.035	0.013	0.01	0	43.9	40.4	70.1	135	126	0	33	32
2015	7	4	1	4	8	0.705	-0.075	4.035	0.016	0.013	0	43	40	70.5	134	125	0	34	32
2015	7	4	1	14	8	0.735	-0.072	4.035	0.01	0.007	0	43.4	40	70.1	134	125	0	33	32
2015	7	4	1	24	8	0.702	-0.092	4.039	0.01	0.007	0	43.4	40.4	69.7	135	126	0	34	32
2015	7	4	1	34	8	0.735	-0.079	4.039	0.013	0.01	0	43.9	40.4	69.2	135	126	0	33	32
2015	7	4	1	44	8	0.719	-0.105	4.039	0.013	0.01	0	43	40	69.7	133	125	0	33	32
2015	7	4	1	54	8	0.686	-0.089	4.039	0.016	0.013	0	43.4	40.4	69.2	135	126	0	34	32
2015	7	4	2	4	8	0.712	-0.085	4.039	0.016	0.013	0	43	39.6	68.8	134	125	0	34	33
2015	7	4	2	14	8	0.696	-0.075	4.039	0.01	0.007	0	43.4	40	69.2	134	125	0	33	32
2015	7	4	2	24	8	0.715	-0.069	4.039	0.01	0.007	0	43	40.4	69.7	134	126	0	34	32
2015	7	4	2	34	8	0.735	-0.079	4.039	0.016	0.016	0	43	39.6	69.2	133	124	0	33	32
2015	7	4	2	44	8	0.722	-0.085	4.039	0.013	0.01	0	42.6	39.6	68.8	133	124	0	34	32
2015	7	4	2	54	8	0.719	-0.069	4.039	0.01	0.007	0	43	39.6	68.8	133	124	0	33	32
2015	7	4	3	4	8	0.715	-0.085	4.039	0.01	0.007	0	43	39.6	68.8	134	125	0	34	33
2015	7	4	3	14	8	0.709	-0.085	4.039	0.01	0.007	0	43	40	68.4	133	125	0	33	32
2015	7	4	3	24	8	0.699	-0.089	4.042	0.013	0.01	0	43.4	40	66.7	134	126	0	33	33
2015	7	4	3	34	8	0.715	-0.085	4.045	0.01	0.007	0	43.9	40.4	67.9	136	126	0	34	32
2015	7	4	3	44	8	0.728	-0.069	4.045	0.01	0.007	0	43.4	40	67.5	134	126	0	33	33
2015	7	4	3	54	8	0.699	-0.082	4.049	0.01	0.007	0	43.4	39.6	67.5	134	125	0	33	33
2015	7	4	4	4	8	0.728	-0.105	4.049	0.01	0.007	0	43.4	40.4	67.9	134	126	0	33	32
2015	7	4	4	14	8	0.702	-0.079	4.052	0.013	0.01	0	43.9	40.9	67.9	136	127	0	34	32
2015	7	4	4	24	8	0.735	-0.089	4.052	0.01	0.007	0	42.6	39.6	67.9	133	125	0	34	33
2015	7	4	4	34	8	0.722	-0.066	4.052	0.01	0.007	0	43.4	40.9	68.4	135	127	0	34	32
2015	7	4	4	44	8	0.709	-0.039	4.055	0.013	0.01	0	43.9	40.4	69.2	135	126	0	33	32
2015	7	4	4	54	8	0.699	-0.069	4.055	0.013	0.01	0	43.4	40.4	69.2	135	126	0	34	32
2015	7	4	5	4	8	0.725	-0.112	4.055	0.016	0.013	0	43	40	69.2	134	125	0	34	32
2015	7	4	5	14	8	0.722	-0.092	4.055	0.01	0.007	0	43.9	40.4	67.5	135	126	0	33	32
2015	7	4	5	24	8	0.732	-0.059	4.055	0.013	0.01	0	43.4	40.4	69.7	135	126	0	34	32
2015	7	4	5	34	8	0.699	-0.069	4.055	0.01	0.007	0	43.4	40.4	70.1	135	126	0	34	32
2015	7	4	5	44	8	0.728	-0.082	4.055	0.01	0.007	0	43.9	40	70.1	135	126	0	33	33
2015	7	4	5	54	8	0.705	-0.098	4.055	0.01	0.007	0	44.3	40	69.7	136	126	0	33	33
2015	7	4	6	4	8	0.725	-0.079	4.058	0.013	0.01	0	43.9	40	70.5	135	126	0	33	33
2015	7	4	6	14	8	0.696	-0.066	4.058	0.01	0.007	0	43.4	40.4	70.5	135	126	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	4	6	24	8	0.732	-0.075	4.058	0.016	0.016	0	43.9	40	71	135	126	0	33	33
2015	7	4	6	34	8	0.712	-0.092	4.058	0.01	0.007	0	43.4	39.6	71.4	134	125	0	33	33
2015	7	4	6	44	8	0.689	-0.059	4.058	0.01	0.007	0	43.9	40.4	70.5	135	126	0	33	32
2015	7	4	6	54	8	0.709	-0.056	4.058	0.013	0.01	0	43.4	40	71.8	134	125	0	33	32
2015	7	4	7	4	8	0.715	-0.108	4.058	0.013	0.01	0	43	40	72.2	134	125	0	34	32
2015	7	4	7	14	8	0.699	-0.069	4.062	0.01	0.007	0	43	40	72.2	134	125	0	34	32
2015	7	4	7	24	8	0.712	-0.066	4.058	0.01	0.007	0	43.4	40	70.1	134	125	0	33	32
2015	7	4	7	34	8	0.702	-0.112	4.062	0.01	0.007	0	43.4	40	72.2	134	125	0	33	32
2015	7	4	7	44	8	0.725	-0.102	4.062	0.01	0.007	0	43.4	40	71.8	134	125	0	33	32
2015	7	4	7	54	8	0.715	-0.092	4.062	0.01	0.007	0	43.4	40	66.7	134	125	0	33	32
2015	7	4	8	4	8	0.719	-0.095	4.062	0.013	0.01	0	43.4	40	67.9	134	125	0	33	32
2015	7	4	8	14	8	0.719	-0.072	4.062	0.01	0.007	0	42.6	39.6	70.5	133	124	0	34	32
2015	7	4	8	24	8	0.696	-0.072	4.062	0.01	0.007	0	43.4	40.4	72.2	135	127	0	34	33
2015	7	4	8	34	8	0.719	-0.105	4.062	0.01	0.007	0	43.9	40.4	71.4	136	127	0	34	33
2015	7	4	8	44	8	0.719	-0.072	4.062	0.013	0.01	0	43.4	40.9	71.4	135	127	0	34	32
2015	7	4	8	54	8	0.709	-0.085	4.062	0.01	0.007	0	43	40.4	71.4	134	126	0	34	32
2015	7	4	9	4	8	0.712	-0.102	4.062	0.013	0.01	0	43	39.6	71.4	134	125	0	34	33
2015	7	4	9	14	8	0.709	-0.085	4.062	0.016	0.013	0	43.4	39.6	71.4	134	125	0	33	33
2015	7	4	9	24	8	0.696	-0.069	4.062	0.01	0.007	0	43.4	40.4	71.8	134	125	0	33	31
2015	7	4	9	34	8	0.735	-0.079	4.062	0.013	0.01	0	43.4	40.9	71.8	135	127	0	34	32
2015	7	4	9	44	8	0.728	-0.092	4.062	0.016	0.016	0	43.4	39.6	71.4	134	125	0	33	33
2015	7	4	9	54	8	0.705	-0.066	4.065	0.013	0.01	0	43.4	40	70.5	135	126	0	34	33
2015	7	4	10	4	8	0.712	-0.085	4.065	0.013	0.01	0	43	40	71	134	126	0	34	33
2015	7	4	10	14	8	0.715	-0.085	4.065	0.01	0.007	0	42.6	39.1	72.2	133	124	0	34	33
2015	7	4	10	24	8	0.725	-0.138	4.062	0.01	0.007	0	42.6	39.1	72.7	133	124	0	34	33
2015	7	4	10	34	8	0.728	-0.118	4.062	0.01	0.007	0	41.7	38.7	65.4	131	123	0	34	33
2015	7	4	10	44	8	0.728	-0.085	4.065	0.01	0.007	0	42.6	39.6	61.1	133	124	0	34	32
2015	7	4	10	54	8	0.709	-0.089	4.065	0.01	0.007	0	41.7	38.7	56.8	131	123	0	34	33
2015	7	4	11	4	8	0.696	-0.072	4.062	0.013	0.01	0	41.7	38.3	56.3	131	122	0	34	33
2015	7	4	11	14	8	0.709	-0.151	4.065	0.013	0.01	0	41.3	37.8	71.4	130	121	0	34	33
2015	7	4	11	24	8	0.719	-0.105	4.065	0.013	0.01	0	42.6	38.7	70.5	132	123	0	33	33
2015	7	4	11	34	8	0.709	-0.135	4.065	0.01	0.007	0	42.1	38.7	72.2	131	122	0	33	32
2015	7	4	11	44	8	0.722	-0.125	4.062	0.01	0.007	0	41.3	38.3	70.5	130	121	0	34	32
2015	7	4	11	54	8	0.712	-0.154	4.062	0.013	0.01	0	43.9	41.3	56.3	135	128	0	33	32
2015	7	4	12	4	8	0.712	-0.066	4.062	0.016	0.013	0	43.4	40.4	56.3	135	126	0	34	32
2015	7	4	12	14	8	0.728	-0.095	4.058	0.01	0.007	0	52.5	49	40.4	156	147	0	34	33
2015	7	4	12	24	8	0.715	-0.108	4.062	0.01	0.007	0	46.9	44.3	49.5	143	135	0	34	32
2015	7	4	12	34	8	0.755	-0.082	4.058	0.01	0.007	0	50.7	47.7	35.7	152	143	0	34	32
2015	7	4	12	44	8	0.758	-0.072	4.058	0.01	0.007	0	46.4	43	46	141	133	0	33	33
2015	7	4	12	54	8	0.748	-0.079	4.058	0.016	0.013	0	50.3	47.3	43.9	151	142	0	34	32
2015	7	4	13	4	8	0.768	-0.066	4.062	0.01	0.007	0	44.7	41.7	49.9	138	129	0	34	32
2015	7	4	13	14	8	0.768	-0.095	4.058	0.01	0.007	0	47.3	43.4	38.3	143	134	0	33	33
2015	7	4	13	24	8	0.778	-0.108	4.062	0.01	0.007	0	43	40	50.7	134	125	0	34	32
2015	7	4	13	34	8	0.741	-0.121	4.062	0.01	0.007	0	43	39.1	44.7	133	123	0	33	32
2015	7	4	13	44	8	0.758	-0.112	4.058	0.01	0.007	0	43.9	40.9	47.7	136	127	0	34	32
2015	7	4	13	54	8	0.692	-0.046	4.062	0.01	0.007	0	50.7	47.3	47.3	151	143	0	33	33
2015	7	4	14	4	8	0.728	-0.108	4.062	0.013	0.01	0	49.9	46.9	48.2	150	141	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	4	14	14	8	0.719	-0.102	4.058	0.01	0.007	0	46	42.6	45.2	141	131	0	34	32
2015	7	4	14	24	8	0.719	-0.069	4.062	0.01	0.007	0	43	40	56.8	134	126	0	34	33
2015	7	4	14	34	8	0.712	-0.102	4.065	0.01	0.007	0	42.6	39.1	67.9	132	123	0	33	32
2015	7	4	14	44	8	0.728	-0.082	4.065	0.01	0.007	0	41.7	39.1	58.9	131	123	0	34	32
2015	7	4	14	54	8	0.702	-0.112	4.065	0.016	0.013	0	42.1	38.7	55	131	123	0	33	33
2015	7	4	15	4	8	0.722	-0.102	4.062	0.01	0.007	0	42.1	39.1	49	132	124	0	34	33
2015	7	4	15	14	8	0.712	-0.102	4.062	0.01	0.007	0	45.2	42.1	40	138	130	0	33	32
2015	7	4	15	24	8	0.712	-0.069	4.065	0.013	0.01	0	42.1	38.7	70.1	131	123	0	33	33
2015	7	4	15	34	8	0.702	-0.095	4.065	0.01	0.007	0	45.2	41.7	43	138	129	0	33	32
2015	7	4	15	44	8	0.728	-0.075	4.065	0.016	0.013	0	42.1	39.6	55	132	124	0	34	32
2015	7	4	15	54	8	0.735	-0.095	4.065	0.01	0.007	0	41.3	38.7	67.1	130	122	0	34	32
2015	7	4	16	4	8	0.738	-0.066	4.065	0.01	0.007	0	42.1	39.6	64.5	131	124	0	33	32
2015	7	4	16	14	8	0.692	-0.095	4.065	0.013	0.01	0	41.3	39.1	61.9	130	123	0	34	32
2015	7	4	16	24	8	0.682	-0.082	4.068	0.01	0.007	0	47.7	45.6	51.2	145	138	0	34	32
2015	7	4	16	34	8	0.666	-0.082	4.068	0.013	0.01	0	50.3	46.9	51.2	151	142	0	34	33
2015	7	4	16	44	8	0.699	-0.082	4.068	0.01	0.007	0	49.9	46.4	50.3	149	141	0	33	33
2015	7	4	16	54	8	0.676	-0.082	4.065	0.01	0.007	0	48.2	45.2	51.2	146	138	0	34	33
2015	7	4	17	4	8	0.728	-0.082	4.068	0.013	0.01	0	47.7	44.3	53.3	145	136	0	34	33
2015	7	4	17	14	8	0.712	-0.072	4.068	0.01	0.007	0	47.3	43.9	55	143	134	0	33	32
2015	7	4	17	24	8	0.715	-0.069	4.068	0.016	0.013	0	45.6	42.6	66.7	140	132	0	34	33
2015	7	4	17	34	8	0.673	-0.036	4.068	0.01	0.007	0	45.2	41.7	67.9	138	130	0	33	33
2015	7	4	17	44	8	0.699	-0.082	4.068	0.01	0.007	0	43.9	40.9	64.5	136	128	0	34	33
2015	7	4	17	54	8	0.696	-0.059	4.072	0.01	0.007	0	46.9	43.9	55	142	134	0	33	32
2015	7	4	18	4	8	0.699	-0.066	4.072	0.01	0.007	0	46.4	43.4	55	142	134	0	34	33
2015	7	4	18	14	8	0.696	-0.089	4.072	0.013	0.01	0	45.6	43	61.1	140	132	0	34	32
2015	7	4	18	24	8	0.682	-0.043	4.072	0.013	0.01	0	46	43	55.9	141	132	0	34	32
2015	7	4	18	34	8	0.728	-0.102	4.068	0.01	0.007	0	49	46	38.3	148	140	0	34	33
2015	7	4	18	44	8	0.728	-0.075	4.075	0.01	0.007	0	52.5	49.5	43.4	156	148	0	34	33
2015	7	4	18	54	8	0.728	-0.082	4.078	0.01	0.007	0	49.9	46	46.4	149	140	0	33	33
2015	7	4	19	4	8	0.735	-0.072	4.075	0.013	0.01	0	46.9	43.9	49	143	134	0	34	32
2015	7	4	19	14	8	0.741	-0.03	4.078	0.01	0.007	0	46.4	43.4	48.6	142	133	0	34	32
2015	7	4	19	24	8	0.722	-0.066	4.078	0.01	0.007	0	46	42.6	54.2	141	132	0	34	33
2015	7	4	19	34	8	0.715	-0.052	4.075	0.013	0.01	0	45.2	42.1	59.8	139	130	0	34	32
2015	7	4	19	44	8	0.745	-0.082	4.075	0.01	0.007	0	44.3	41.3	66.2	137	129	0	34	33
2015	7	4	19	54	8	0.696	-0.105	4.075	0.013	0.01	0	44.7	41.7	64.9	138	129	0	34	32
2015	7	4	20	4	8	0.722	-0.102	4.078	0.01	0.007	0	45.2	41.7	61.9	139	130	0	34	33
2015	7	4	20	14	8	0.728	-0.085	4.081	0.01	0.007	0	46	42.6	57.2	140	131	0	33	32
2015	7	4	20	24	8	0.732	-0.069	4.081	0.016	0.013	0	45.6	42.1	59.3	140	131	0	34	33
2015	7	4	20	34	8	0.728	-0.102	4.085	0.01	0.007	0	44.7	41.7	65.8	138	129	0	34	32
2015	7	4	20	44	8	0.732	-0.069	4.085	0.01	0.007	0	45.2	41.7	66.7	138	129	0	33	32
2015	7	4	20	54	8	0.715	-0.052	4.088	0.01	0.007	0	44.7	41.3	65.8	138	129	0	34	33
2015	7	4	21	4	8	0.719	-0.062	4.088	0.016	0.013	0	45.2	42.1	65.8	138	130	0	33	32
2015	7	4	21	14	8	0.702	-0.062	4.091	0.01	0.007	0	44.3	41.3	67.1	137	128	0	34	32
2015	7	4	21	24	8	0.712	-0.085	4.091	0.01	0.007	0	44.7	40.9	67.1	137	128	0	33	33
2015	7	4	21	34	8	0.709	-0.089	4.091	0.01	0.007	0	44.3	41.3	67.5	136	128	0	33	32
2015	7	4	21	44	8	0.715	-0.092	4.091	0.01	0.007	0	43.4	40.4	68.8	135	127	0	34	33
2015	7	4	21	54	8	0.738	-0.092	4.094	0.013	0.01	0	43.4	40.4	68.4	135	127	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	4	22	4	8	0.728	-0.092	4.094	0.01	0.007	0	43.4	40.4	70.1	135	126	0	34	32
2015	7	4	22	14	8	0.745	-0.082	4.094	0.01	0.007	0	43.4	40.4	65.4	135	126	0	34	32
2015	7	4	22	24	8	0.738	-0.049	4.094	0.01	0.007	0	45.2	41.7	69.2	138	129	0	33	32
2015	7	4	22	34	8	0.735	-0.046	4.094	0.01	0.007	0	43.9	40	68.8	135	126	0	33	33
2015	7	4	22	44	8	0.692	-0.072	4.094	0.013	0.01	0	44.7	40.9	68.8	137	128	0	33	33
2015	7	4	22	54	8	0.728	-0.105	4.098	0.013	0.01	0	43.9	40.9	70.1	136	127	0	34	32
2015	7	4	23	4	8	0.712	-0.082	4.098	0.01	0.007	0	44.3	41.3	70.5	137	128	0	34	32
2015	7	4	23	14	8	0.712	-0.066	4.098	0.01	0.007	0	44.3	40.9	70.5	136	127	0	33	32
2015	7	4	23	24	8	0.728	-0.098	4.098	0.013	0.01	0	43.9	40.9	70.5	136	127	0	34	32
2015	7	4	23	34	8	0.712	-0.095	4.098	0.01	0.007	0	43.9	40.9	72.2	136	127	0	34	32
2015	7	4	23	44	8	0.692	-0.072	4.098	0.01	0.007	0	44.3	40.9	71.8	137	128	0	34	33
2015	7	4	23	54	8	0.728	-0.069	4.101	0.016	0.013	0	43.9	40.4	71.4	135	127	0	33	33
2015	7	5	0	4	8	0.738	-0.082	4.101	0.013	0.01	0	44.3	40.4	71.8	136	127	0	33	33
2015	7	5	0	14	8	0.715	-0.066	4.101	0.01	0.007	0	43.4	40	72.2	135	126	0	34	33
2015	7	5	0	24	8	0.699	-0.059	4.101	0.01	0.007	0	43.4	40	72.2	135	126	0	34	33
2015	7	5	0	34	8	0.712	-0.072	4.101	0.01	0.007	0	43.4	40.9	71.8	135	127	0	34	32
2015	7	5	0	44	8	0.738	-0.085	4.101	0.01	0.007	0	43.4	40	72.2	134	125	0	33	32
2015	7	5	0	54	8	0.715	-0.092	4.101	0.01	0.007	0	43	40	71.8	134	125	0	34	32
2015	7	5	1	4	8	0.745	-0.092	4.101	0.01	0.007	0	43	39.1	71.4	133	124	0	33	33
2015	7	5	1	14	8	0.692	-0.092	4.101	0.01	0.007	0	43.4	40.9	71.8	135	126	0	34	31
2015	7	5	1	24	8	0.719	-0.062	4.101	0.01	0.007	0	43	40.9	71.4	135	127	0	35	32
2015	7	5	1	34	8	0.748	-0.052	4.101	0.016	0.013	0	44.3	40.4	71.4	136	127	0	33	33
2015	7	5	1	44	8	0.725	-0.066	4.104	0.013	0.01	0	43.4	40.4	71	135	126	0	34	32
2015	7	5	1	54	8	0.755	-0.075	4.104	0.013	0.01	0	43	40	70.5	134	126	0	34	33
2015	7	5	2	4	8	0.709	-0.085	4.104	0.01	0.007	0	44.3	40.9	71	136	127	0	33	32
2015	7	5	2	14	8	0.725	-0.108	4.104	0.01	0.007	0	43.4	40.4	70.5	135	126	0	34	32
2015	7	5	2	24	8	0.751	-0.069	4.104	0.01	0.007	0	43.9	40	70.5	135	126	0	33	33
2015	7	5	2	34	8	0.709	-0.095	4.104	0.013	0.01	0	43.9	40.4	70.1	136	127	0	34	33
2015	7	5	2	44	8	0.699	-0.059	4.104	0.013	0.01	0	43.4	40.4	69.7	135	126	0	34	32
2015	7	5	2	54	8	0.722	-0.082	4.104	0.016	0.016	0	43	39.6	70.1	134	125	0	34	33
2015	7	5	3	4	8	0.732	-0.069	4.108	0.013	0.01	0	43.9	40	69.7	135	126	0	33	33
2015	7	5	3	14	8	0.741	-0.066	4.108	0.01	0.007	0	43	39.6	69.2	134	125	0	34	33
2015	7	5	3	24	8	0.738	-0.052	4.108	0.016	0.013	0	43	40	68.8	134	125	0	34	32
2015	7	5	3	34	8	0.728	-0.069	4.108	0.01	0.007	0	43.9	40.4	68.4	136	127	0	34	33
2015	7	5	3	44	8	0.719	-0.085	4.108	0.01	0.007	0	44.3	41.3	67.1	137	128	0	34	32
2015	7	5	3	54	8	0.692	-0.069	4.108	0.01	0.007	0	43.9	40.4	68.8	136	127	0	34	33
2015	7	5	4	4	8	0.741	-0.079	4.108	0.01	0.007	0	43.4	40.4	68.4	135	126	0	34	32
2015	7	5	4	14	8	0.679	-0.089	4.111	0.01	0.007	0	43	40	67.5	134	126	0	34	33
2015	7	5	4	24	8	0.719	-0.039	4.114	0.01	0.007	0	43.4	40.4	67.5	135	126	0	34	32
2015	7	5	4	34	8	0.728	-0.085	4.114	0.01	0.007	0	43	40.4	67.1	134	126	0	34	32
2015	7	5	4	44	8	0.725	-0.075	4.117	0.01	0.007	0	43.9	40	65.8	136	126	0	34	33
2015	7	5	4	54	8	0.761	-0.095	4.121	0.01	0.007	0	43	39.6	67.9	134	125	0	34	33
2015	7	5	5	4	8	0.732	-0.082	4.124	0.01	0.007	0	43.4	40	68.4	134	125	0	33	32
2015	7	5	5	14	8	0.738	-0.069	4.124	0.016	0.013	0	43	39.1	68.4	134	125	0	34	34
2015	7	5	5	24	8	0.738	-0.085	4.124	0.01	0.007	0	43	39.6	68.4	134	124	0	34	32
2015	7	5	5	34	8	0.728	-0.056	4.124	0.01	0.007	0	43	40	69.2	134	125	0	34	32
2015	7	5	5	44	8	0.725	-0.098	4.127	0.01	0.007	0	42.6	39.1	70.1	133	124	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	5	5	54	8	0.728	-0.069	4.127	0.01	0.007	0	43	40.4	70.1	134	126	0	34	32
2015	7	5	6	4	8	0.725	-0.069	4.127	0.01	0.007	0	45.2	41.7	66.7	139	130	0	34	33
2015	7	5	6	14	8	0.728	-0.105	4.127	0.01	0.007	0	42.6	39.1	71	133	124	0	34	33
2015	7	5	6	24	8	0.722	-0.072	4.127	0.01	0.007	0	43	39.6	71	133	124	0	33	32
2015	7	5	6	34	8	0.702	-0.052	4.127	0.01	0.007	0	42.6	38.7	71.8	133	123	0	34	33
2015	7	5	6	44	8	0.738	-0.069	4.131	0.01	0.007	0	41.7	38.3	71.8	131	122	0	34	33
2015	7	5	6	54	8	0.725	-0.069	4.131	0.013	0.01	0	42.6	39.1	71.8	133	124	0	34	33
2015	7	5	7	4	8	0.748	-0.082	4.131	0.01	0.007	0	42.1	38.7	71.8	132	123	0	34	33
2015	7	5	7	14	8	0.738	-0.085	4.131	0.01	0.007	0	41.7	38.7	72.2	131	122	0	34	32
2015	7	5	7	24	8	0.715	-0.052	4.131	0.01	0.007	0	42.1	39.1	71.8	132	124	0	34	33
2015	7	5	7	34	8	0.728	-0.085	4.131	0.013	0.01	0	42.6	38.7	72.2	132	123	0	33	33
2015	7	5	7	44	8	0.719	-0.098	4.131	0.01	0.007	0	42.1	38.7	72.2	132	123	0	34	33
2015	7	5	7	54	8	0.755	-0.095	4.131	0.01	0.007	0	41.3	38.3	71.8	130	122	0	34	33
2015	7	5	8	4	8	0.732	-0.131	4.134	0.013	0.01	0	41.3	37.8	72.2	130	121	0	34	33
2015	7	5	8	14	8	0.748	-0.092	4.134	0.01	0.007	0	41.3	37.8	72.2	130	121	0	34	33
2015	7	5	8	24	8	0.738	-0.092	4.134	0.013	0.01	0	41.3	38.3	71.8	130	121	0	34	32
2015	7	5	8	34	8	0.735	-0.085	4.134	0.01	0.007	0	40.9	38.3	71.8	129	121	0	34	32
2015	7	5	8	44	8	0.745	-0.085	4.134	0.01	0.007	0	40.9	37.4	72.2	129	120	0	34	33
2015	7	5	8	54	8	0.738	-0.098	4.134	0.01	0.007	0	40.4	37.8	71.8	128	120	0	34	32
2015	7	5	9	4	8	0.692	-0.098	4.134	0.013	0.01	0	41.3	38.3	71.8	129	121	0	33	32
2015	7	5	9	14	8	0.725	-0.066	4.134	0.01	0.007	0	40	37.4	72.2	128	120	0	35	33
2015	7	5	9	24	8	0.745	-0.105	4.134	0.013	0.01	0	40.4	37	72.2	128	119	0	34	33
2015	7	5	9	34	8	0.748	-0.108	4.137	0.01	0.007	0	40.9	37	71.8	128	119	0	33	33
2015	7	5	9	44	8	0.778	-0.089	4.137	0.013	0.01	0	40	37	72.2	127	119	0	34	33
2015	7	5	9	54	8	0.735	-0.102	4.137	0.01	0.007	0	40.4	37.4	71.8	128	120	0	34	33
2015	7	5	10	4	8	0.722	-0.072	4.137	0.013	0.01	0	40.9	37.8	71.8	129	120	0	34	32
2015	7	5	10	14	8	0.728	-0.056	4.137	0.01	0.007	0	40.4	37.8	71.4	128	120	0	34	32
2015	7	5	10	24	8	0.738	-0.098	4.137	0.013	0.01	0	40.4	36.5	71.4	127	119	0	33	34
2015	7	5	10	34	8	0.771	-0.082	4.137	0.01	0.007	0	40.4	37	71	128	119	0	34	33
2015	7	5	10	44	8	0.755	-0.135	4.137	0.01	0.007	0	40.4	37	71.8	127	119	0	33	33
2015	7	5	10	54	8	0.751	-0.128	4.137	0.013	0.01	0	40.4	37	70.1	128	119	0	34	33
2015	7	5	11	4	8	0.771	-0.131	4.137	0.01	0.007	0	40	36.5	71.8	127	118	0	34	33
2015	7	5	11	14	8	0.755	-0.118	4.137	0.016	0.013	0	40	37	70.5	127	118	0	34	32
2015	7	5	11	24	8	0.761	-0.135	4.137	0.01	0.007	0	40.4	37.4	70.5	128	119	0	34	32
2015	7	5	11	34	8	0.738	-0.115	4.14	0.01	0.007	0	40	36.5	58.9	127	118	0	34	33
2015	7	5	11	44	8	0.755	-0.098	4.137	0.01	0.007	0	39.6	36.5	64.9	126	118	0	34	33
2015	7	5	11	54	8	0.696	-0.135	4.137	0.01	0.007	0	39.1	36.5	65.4	126	118	0	35	33
2015	7	5	12	4	8	0.758	-0.092	4.14	0.01	0.007	0	39.6	37	59.3	126	118	0	34	32
2015	7	5	12	14	8	0.722	-0.157	4.14	0.01	0.007	0	40.4	37	58	127	119	0	33	33
2015	7	5	12	24	8	0.702	-0.151	4.14	0.01	0.007	0	41.3	38.3	52.5	130	122	0	34	33
2015	7	5	12	34	8	0.738	-0.151	4.14	0.01	0.007	0	40.4	37.4	56.8	128	119	0	34	32
2015	7	5	12	44	8	0.722	-0.148	4.14	0.01	0.007	0	40.4	37.4	55.5	128	119	0	34	32
2015	7	5	12	54	8	0.722	-0.171	4.14	0.01	0.007	0	40.4	37.4	55	128	120	0	34	33
2015	7	5	13	4	8	0.669	-0.164	4.144	0.013	0.01	0	41.3	38.7	48.2	130	122	0	34	32
2015	7	5	13	14	8	0.732	-0.164	4.144	0.01	0.007	0	41.3	37.8	54.2	130	121	0	34	33
2015	7	5	13	24	8	0.732	-0.148	4.14	0.01	0.007	0	46	42.1	44.7	141	131	0	34	33
2015	7	5	13	34	8	0.676	-0.105	4.14	0.016	0.013	0	45.6	40.4	46.9	139	127	0	33	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	5	13	44	8	0.682	-0.148	4.144	0.013	0.01	0	44.7	40.9	48.6	138	128	0	34	33
2015	7	5	13	54	8	0.725	-0.174	4.144	0.01	0.007	0	41.7	38.3	50.7	131	122	0	34	33
2015	7	5	14	4	8	0.748	-0.098	4.144	0.01	0.007	0	40.9	37.4	56.3	129	120	0	34	33
2015	7	5	14	14	8	0.732	-0.066	4.144	0.01	0.007	0	41.3	37.8	57.2	130	120	0	34	32
2015	7	5	14	24	8	0.751	-0.062	4.144	0.013	0.01	0	41.7	38.3	61.1	131	122	0	34	33
2015	7	5	14	34	8	0.702	-0.072	4.144	0.013	0.01	0	42.1	38.7	58	132	123	0	34	33
2015	7	5	14	44	8	0.761	-0.089	4.144	0.01	0.007	0	42.6	38.7	58.5	132	123	0	33	33
2015	7	5	14	54	8	0.745	-0.072	4.144	0.01	0.007	0	41.3	37.8	63.6	130	121	0	34	33
2015	7	5	15	4	8	0.755	-0.085	4.144	0.01	0.007	0	41.3	38.3	63.2	130	121	0	34	32
2015	7	5	15	14	8	0.715	-0.082	4.147	0.013	0.01	0	41.7	37.8	58.9	130	121	0	33	33
2015	7	5	15	24	8	0.751	-0.049	4.15	0.013	0.01	0	41.7	38.7	54.2	131	123	0	34	33
2015	7	5	15	34	8	0.735	-0.062	4.15	0.01	0.007	0	43.9	40.4	54.2	136	127	0	34	33
2015	7	5	15	44	8	0.751	-0.098	4.15	0.01	0.007	0	43.4	40.4	58.9	135	126	0	34	32
2015	7	5	15	54	8	0.732	-0.026	4.15	0.01	0.007	0	46.4	43	55.9	142	133	0	34	33
2015	7	5	16	4	8	0.732	-0.085	4.154	0.01	0.007	0	45.6	42.1	51.6	140	131	0	34	33
2015	7	5	16	14	8	0.751	-0.085	4.154	0.013	0.01	0	44.3	40.9	64.1	137	128	0	34	33
2015	7	5	16	24	8	0.732	-0.066	4.154	0.01	0.007	0	43.4	40	66.2	135	126	0	34	33
2015	7	5	16	34	8	0.738	-0.075	4.154	0.01	0.007	0	43	40	67.1	134	125	0	34	32
2015	7	5	16	44	8	0.738	-0.131	4.157	0.01	0.007	0	42.1	38.7	65.8	132	123	0	34	33
2015	7	5	16	54	8	0.745	-0.095	4.157	0.01	0.007	0	42.1	38.7	67.9	131	123	0	33	33
2015	7	5	17	4	8	0.728	-0.095	4.163	0.01	0.007	0	42.6	39.1	67.5	133	124	0	34	33
2015	7	5	17	14	8	0.758	-0.069	4.163	0.01	0.007	0	42.1	39.1	66.7	132	123	0	34	32
2015	7	5	17	24	8	0.728	-0.128	4.163	0.01	0.007	0	41.7	38.7	67.5	131	123	0	34	33
2015	7	5	17	34	8	0.755	-0.085	4.163	0.01	0.007	0	41.7	38.7	68.8	131	123	0	34	33
2015	7	5	17	44	8	0.751	-0.138	4.163	0.01	0.007	0	42.1	38.7	69.2	131	122	0	33	32
2015	7	5	17	54	8	0.738	-0.098	4.163	0.01	0.007	0	41.3	38.3	68.8	130	121	0	34	32
2015	7	5	18	4	8	0.748	-0.131	4.163	0.013	0.01	0	41.3	37.8	63.2	130	121	0	34	33
2015	7	5	18	14	8	0.768	-0.118	4.163	0.01	0.007	0	41.3	38.3	52	130	121	0	34	32
2015	7	5	18	24	8	0.751	-0.079	4.167	0.01	0.007	0	41.3	38.3	51.2	130	122	0	34	33
2015	7	5	18	34	8	0.755	-0.121	4.163	0.013	0.01	0	42.1	38.3	55	131	122	0	33	33
2015	7	5	18	44	8	0.771	-0.092	4.163	0.01	0.007	0	42.1	39.6	52	132	124	0	34	32
2015	7	5	18	54	8	0.774	-0.085	4.163	0.01	0.007	0	42.6	39.6	52.5	133	124	0	34	32
2015	7	5	19	4	8	0.748	-0.052	4.163	0.01	0.007	0	42.6	39.6	49	132	124	0	33	32
2015	7	5	19	14	8	0.719	-0.085	4.167	0.01	0.007	0	43	39.1	51.2	133	124	0	33	33
2015	7	5	19	24	8	0.755	-0.098	4.167	0.01	0.007	0	42.6	39.1	51.6	132	124	0	33	33
2015	7	5	19	34	8	0.774	-0.092	4.167	0.013	0.01	0	42.6	39.6	49	133	124	0	34	32
2015	7	5	19	44	8	0.758	-0.082	4.17	0.01	0.007	0	41.7	38.7	70.5	131	123	0	34	33
2015	7	5	19	54	8	0.771	-0.049	4.17	0.01	0.007	0	41.7	38.3	71.8	131	122	0	34	33
2015	7	5	20	4	8	0.768	-0.105	4.173	0.01	0.007	0	41.7	39.1	70.5	132	124	0	35	33
2015	7	5	20	14	8	0.758	-0.079	4.173	0.013	0.01	0	42.6	40	71.8	133	125	0	34	32
2015	7	5	20	24	8	0.738	-0.098	4.173	0.01	0.007	0	42.6	39.1	72.2	133	124	0	34	33
2015	7	5	20	34	8	0.725	-0.069	4.173	0.01	0.007	0	42.6	38.7	72.2	132	123	0	33	33
2015	7	5	20	44	8	0.719	-0.069	4.173	0.01	0.007	0	43	39.6	68.4	133	124	0	33	32
2015	7	5	20	54	8	0.728	-0.072	4.177	0.01	0.007	0	42.6	39.1	70.5	133	124	0	34	33
2015	7	5	21	4	8	0.722	-0.033	4.177	0.013	0.01	0	42.6	39.1	67.5	133	124	0	34	33
2015	7	5	21	14	8	0.771	-0.092	4.177	0.013	0.01	0	43	40	67.5	134	126	0	34	33
2015	7	5	21	24	8	0.725	-0.049	4.177	0.01	0.007	0	43.9	41.3	67.9	136	128	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	5	21	34	8	0.741	-0.108	4.177	0.01	0.007	0	42.6	39.6	70.5	133	124	0	34	32
2015	7	5	21	44	8	0.761	-0.069	4.177	0.016	0.013	0	42.6	38.7	70.5	132	123	0	33	33
2015	7	5	21	54	8	0.751	-0.069	4.177	0.01	0.007	0	43	39.6	70.5	134	125	0	34	33
2015	7	5	22	4	8	0.709	-0.046	4.18	0.013	0.01	0	43	39.6	70.5	134	125	0	34	33
2015	7	5	22	14	8	0.761	-0.079	4.18	0.01	0.007	0	42.1	39.6	70.1	132	124	0	34	32
2015	7	5	22	24	8	0.758	-0.089	4.18	0.01	0.007	0	42.6	39.6	69.7	133	124	0	34	32
2015	7	5	22	34	8	0.748	-0.102	4.18	0.01	0.007	0	43	40	69.2	134	125	0	34	32
2015	7	5	22	44	8	0.735	-0.052	4.18	0.01	0.007	0	44.3	40.4	69.7	136	127	0	33	33
2015	7	5	22	54	8	0.719	-0.062	4.183	0.01	0.007	0	43.4	40	69.2	134	126	0	33	33
2015	7	5	23	4	8	0.784	-0.079	4.183	0.013	0.01	0	43	39.1	70.1	133	124	0	33	33
2015	7	5	23	14	8	0.709	-0.069	4.183	0.01	0.007	0	43	40.4	67.9	134	125	0	34	31
2015	7	5	23	24	8	0.768	-0.089	4.183	0.01	0.007	0	42.6	39.6	67.5	133	125	0	34	33
2015	7	5	23	34	8	0.741	-0.098	4.183	0.01	0.007	0	43	40	68.8	134	125	0	34	32
2015	7	5	23	44	8	0.758	-0.079	4.186	0.01	0.007	0	43	40	68.8	133	125	0	33	32
2015	7	5	23	54	8	0.741	-0.102	4.186	0.01	0.007	0	43.4	40	68.4	134	125	0	33	32
2015	7	6	0	4	8	0.764	-0.059	4.186	0.01	0.007	0	42.1	39.1	68.4	132	123	0	34	32
2015	7	6	0	14	8	0.771	-0.066	4.186	0.01	0.007	0	42.1	39.1	67.1	132	124	0	34	33
2015	7	6	0	24	8	0.758	-0.079	4.186	0.016	0.013	0	42.6	40	67.5	133	125	0	34	32
2015	7	6	0	34	8	0.735	-0.052	4.19	0.01	0.007	0	42.1	39.6	67.1	133	125	0	35	33
2015	7	6	0	44	8	0.787	-0.059	4.193	0.01	0.007	0	43	39.6	67.5	133	125	0	33	33
2015	7	6	0	54	8	0.741	-0.043	4.196	0.01	0.007	0	43	39.6	67.5	134	125	0	34	33
2015	7	6	1	4	8	0.741	-0.082	4.199	0.01	0.007	0	42.6	39.6	67.9	133	124	0	34	32
2015	7	6	1	14	8	0.771	-0.075	4.203	0.01	0.007	0	42.1	39.1	68.4	132	124	0	34	33
2015	7	6	1	24	8	0.735	-0.056	4.203	0.01	0.007	0	42.6	39.6	68.4	133	124	0	34	32
2015	7	6	1	34	8	0.787	-0.075	4.203	0.013	0.01	0	41.7	39.1	69.2	131	123	0	34	32
2015	7	6	1	44	8	0.715	-0.043	4.203	0.01	0.007	0	42.1	39.1	69.2	132	124	0	34	33
2015	7	6	1	54	8	0.748	-0.066	4.206	0.01	0.007	0	42.6	38.7	70.1	133	123	0	34	33
2015	7	6	2	4	8	0.755	-0.072	4.206	0.016	0.013	0	42.1	38.7	69.2	132	123	0	34	33
2015	7	6	2	14	8	0.732	-0.049	4.206	0.01	0.007	0	42.1	39.1	70.1	132	123	0	34	32
2015	7	6	2	24	8	0.774	-0.085	4.206	0.01	0.007	0	42.6	38.7	71	132	123	0	33	33
2015	7	6	2	34	8	0.771	-0.115	4.206	0.01	0.007	0	42.6	38.7	71.4	132	123	0	33	33
2015	7	6	2	44	8	0.771	-0.098	4.209	0.013	0.01	0	42.1	38.3	71.4	132	122	0	34	33
2015	7	6	2	54	8	0.781	-0.102	4.209	0.01	0.007	0	42.1	38.7	71.8	131	122	0	33	32
2015	7	6	3	4	8	0.761	-0.072	4.209	0.013	0.01	0	41.7	38.3	71.4	131	122	0	34	33
2015	7	6	3	14	8	0.735	-0.079	4.209	0.01	0.007	0	41.7	38.7	72.2	131	122	0	34	32
2015	7	6	3	24	8	0.771	-0.125	4.209	0.01	0.007	0	42.1	38.7	71.8	132	123	0	34	33
2015	7	6	3	34	8	0.774	-0.102	4.209	0.01	0.007	0	42.1	38.3	71.8	131	122	0	33	33
2015	7	6	3	44	8	0.758	-0.052	4.209	0.01	0.007	0	42.6	39.1	71.8	133	123	0	34	32
2015	7	6	3	54	8	0.745	-0.072	4.213	0.01	0.007	0	42.1	38.7	71	132	123	0	34	33
2015	7	6	4	4	8	0.745	-0.089	4.213	0.013	0.01	0	41.7	38.3	71.8	131	122	0	34	33
2015	7	6	4	14	8	0.738	-0.033	4.213	0.016	0.013	0	42.1	38.7	70.5	132	123	0	34	33
2015	7	6	4	24	8	0.764	-0.108	4.213	0.01	0.007	0	41.7	38.7	71.4	131	122	0	34	32
2015	7	6	4	34	8	0.784	-0.072	4.213	0.01	0.007	0	42.1	38.7	71	132	123	0	34	33
2015	7	6	4	44	8	0.774	-0.092	4.213	0.01	0.007	0	41.7	38.7	70.1	131	122	0	34	32
2015	7	6	4	54	8	0.758	-0.098	4.216	0.01	0.007	0	41.3	37.8	70.5	130	121	0	34	33
2015	7	6	5	4	8	0.748	-0.092	4.216	0.01	0.007	0	41.3	38.3	70.5	130	122	0	34	33
2015	7	6	5	14	8	0.738	-0.059	4.216	0.01	0.007	0	41.7	38.3	70.1	130	121	0	33	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	6	5	24	8	0.761	-0.082	4.216	0.01	0.007	0	41.3	37.8	69.2	130	121	0	34	33
2015	7	6	5	34	8	0.761	-0.105	4.216	0.01	0.007	0	40.9	37.8	69.2	129	121	0	34	33
2015	7	6	5	44	8	0.738	-0.072	4.216	0.01	0.007	0	40.9	37.4	70.1	129	120	0	34	33
2015	7	6	5	54	8	0.751	-0.066	4.216	0.01	0.007	0	40.4	37.8	68.4	129	121	0	35	33
2015	7	6	6	4	8	0.774	-0.098	4.216	0.01	0.007	0	40.9	37.8	69.7	129	121	0	34	33
2015	7	6	6	14	8	0.732	-0.069	4.216	0.01	0.007	0	40.4	37	69.2	128	119	0	34	33
2015	7	6	6	24	8	0.768	-0.108	4.219	0.01	0.007	0	40.4	37.4	68.4	128	119	0	34	32
2015	7	6	6	34	8	0.755	-0.069	4.219	0.01	0.007	0	40	37	68.8	127	118	0	34	32
2015	7	6	6	44	8	0.755	-0.072	4.219	0.013	0.01	0	40.4	37	68.4	128	119	0	34	33
2015	7	6	6	54	8	0.751	-0.049	4.219	0.01	0.007	0	39.6	36.5	68.8	126	118	0	34	33
2015	7	6	7	4	8	0.794	-0.066	4.219	0.016	0.013	0	39.6	36.5	68.8	126	117	0	34	32
2015	7	6	7	14	8	0.761	-0.089	4.219	0.013	0.01	0	39.6	36.1	67.9	126	117	0	34	33
2015	7	6	7	24	8	0.751	-0.075	4.219	0.01	0.007	0	39.6	36.1	67.9	126	117	0	34	33
2015	7	6	7	34	8	0.774	-0.075	4.222	0.01	0.007	0	39.6	36.1	67.9	126	117	0	34	33
2015	7	6	7	44	8	0.751	-0.085	4.222	0.013	0.01	0	39.6	36.1	66.7	126	117	0	34	33
2015	7	6	7	54	8	0.748	-0.082	4.222	0.01	0.007	0	39.6	36.5	67.1	126	117	0	34	32
2015	7	6	8	4	8	0.741	-0.118	4.226	0.01	0.007	0	39.6	35.7	67.9	126	117	0	34	34
2015	7	6	8	14	8	0.771	-0.095	4.226	0.013	0.01	0	39.1	36.1	67.5	126	117	0	35	33
2015	7	6	8	24	8	0.774	-0.098	4.229	0.01	0.007	0	39.6	36.1	67.9	126	117	0	34	33
2015	7	6	8	34	8	0.755	-0.056	4.232	0.01	0.007	0	39.6	36.5	67.9	126	117	0	34	32
2015	7	6	8	44	8	0.735	-0.066	4.232	0.016	0.013	0	39.6	36.1	67.9	126	117	0	34	33
2015	7	6	8	54	8	0.771	-0.079	4.232	0.01	0.007	0	39.6	36.5	68.4	126	118	0	34	33
2015	7	6	9	4	8	0.745	-0.056	4.232	0.01	0.007	0	39.6	36.5	68.8	126	117	0	34	32
2015	7	6	9	14	8	0.761	-0.105	4.232	0.016	0.013	0	40.4	37	67.9	128	119	0	34	33
2015	7	6	9	24	8	0.774	-0.092	4.232	0.01	0.007	0	40	37	68.4	127	119	0	34	33
2015	7	6	9	34	8	0.761	-0.082	4.236	0.01	0.007	0	40	37	67.9	127	119	0	34	33
2015	7	6	9	44	8	0.784	-0.066	4.236	0.01	0.007	0	40	37.8	68.4	128	120	0	35	32
2015	7	6	9	54	8	0.778	-0.095	4.236	0.01	0.007	0	40.4	37	68.4	128	119	0	34	33
2015	7	6	10	4	8	0.781	-0.095	4.236	0.01	0.007	0	40	36.5	68.8	127	118	0	34	33
2015	7	6	10	14	8	0.801	-0.082	4.236	0.01	0.007	0	40.4	37.8	68.4	128	120	0	34	32
2015	7	6	10	24	8	0.774	-0.115	4.236	0.01	0.007	0	40	36.5	69.2	127	118	0	34	33
2015	7	6	10	34	8	0.774	-0.135	4.236	0.01	0.007	0	39.6	36.5	68.8	126	118	0	34	33
2015	7	6	10	44	8	0.758	-0.115	4.236	0.013	0.01	0	39.6	36.5	69.2	126	118	0	34	33
2015	7	6	10	54	8	0.797	-0.118	4.236	0.01	0.007	0	39.6	36.5	68.4	126	118	0	34	33
2015	7	6	11	4	8	0.778	-0.144	4.236	0.013	0.01	0	39.6	36.5	68.4	126	118	0	34	33
2015	7	6	11	14	8	0.768	-0.151	4.236	0.01	0.007	0	39.6	36.1	67.1	126	117	0	34	33
2015	7	6	11	24	8	0.774	-0.148	4.236	0.01	0.007	0	39.1	36.1	59.3	125	117	0	34	33
2015	7	6	11	34	8	0.748	-0.138	4.236	0.01	0.007	0	40	36.5	63.6	127	118	0	34	33
2015	7	6	11	44	8	0.755	-0.121	4.236	0.01	0.007	0	39.6	36.5	61.9	126	118	0	34	33
2015	7	6	11	54	8	0.794	-0.112	4.236	0.01	0.007	0	40	36.5	55	127	118	0	34	33
2015	7	6	12	4	8	0.771	-0.148	4.236	0.01	0.007	0	39.6	36.5	53.8	126	118	0	34	33
2015	7	6	12	14	8	0.755	-0.118	4.236	0.013	0.01	0	39.6	36.5	51.2	126	118	0	34	33
2015	7	6	12	24	8	0.761	-0.128	4.236	0.01	0.007	0	40	36.5	53.3	127	118	0	34	33
2015	7	6	12	34	8	0.761	-0.144	4.236	0.013	0.01	0	39.6	37.4	54.2	127	119	0	35	32
2015	7	6	12	44	8	0.748	-0.148	4.236	0.01	0.007	0	39.1	36.5	54.2	126	118	0	35	33
2015	7	6	12	54	8	0.755	-0.128	4.236	0.01	0.007	0	39.6	36.1	58.9	126	117	0	34	33
2015	7	6	13	4	8	0.755	-0.118	4.236	0.013	0.01	0	40	36.5	52	127	118	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	6	13	14	8	0.768	-0.138	4.236	0.01	0.007	0	39.6	36.5	61.5	126	118	0	34	33
2015	7	6	13	24	8	0.774	-0.115	4.236	0.016	0.013	0	39.6	36.5	55.5	126	118	0	34	33
2015	7	6	13	34	8	0.787	-0.161	4.239	0.01	0.007	0	40	36.5	50.3	127	118	0	34	33
2015	7	6	13	44	8	0.758	-0.164	4.236	0.01	0.007	0	40	36.5	55.5	126	117	0	33	32
2015	7	6	13	54	8	0.771	-0.112	4.239	0.01	0.007	0	39.1	35.7	65.4	125	116	0	34	33
2015	7	6	14	4	8	0.784	-0.138	4.239	0.01	0.007	0	39.6	36.5	57.2	126	117	0	34	32
2015	7	6	14	14	8	0.761	-0.144	4.239	0.01	0.007	0	40	37	53.8	127	118	0	34	32
2015	7	6	14	24	8	0.755	-0.161	4.239	0.01	0.007	0	39.1	36.5	65.8	125	117	0	34	32
2015	7	6	14	34	8	0.771	-0.105	4.242	0.01	0.007	0	39.1	35.7	61.1	125	116	0	34	33
2015	7	6	14	44	8	0.771	-0.082	4.239	0.01	0.007	0	39.1	36.5	57.2	125	117	0	34	32
2015	7	6	14	54	8	0.735	-0.135	4.242	0.01	0.007	0	39.1	36.1	57.2	125	117	0	34	33
2015	7	6	15	4	8	0.761	-0.144	4.242	0.01	0.007	0	39.6	36.5	62.4	126	118	0	34	33
2015	7	6	15	14	8	0.732	-0.102	4.242	0.01	0.007	0	39.6	36.1	58.9	126	117	0	34	33
2015	7	6	15	24	8	0.781	-0.092	4.242	0.01	0.007	0	39.6	36.1	57.6	126	117	0	34	33
2015	7	6	15	34	8	0.758	-0.066	4.245	0.013	0.01	0	40	36.1	55.5	126	117	0	33	33
2015	7	6	15	44	8	0.751	-0.157	4.242	0.01	0.007	0	39.6	35.7	55.5	125	116	0	33	33
2015	7	6	15	54	8	0.768	-0.131	4.245	0.01	0.007	0	39.6	36.1	53.3	125	117	0	33	33
2015	7	6	16	4	8	0.758	-0.098	4.245	0.01	0.007	0	39.6	37	55.9	126	118	0	34	32
2015	7	6	16	14	8	0.748	-0.085	4.245	0.01	0.007	0	39.6	36.5	58	126	117	0	34	32
2015	7	6	16	24	8	0.791	-0.085	4.245	0.01	0.007	0	39.6	35.7	54.6	126	117	0	34	34
2015	7	6	16	34	8	0.781	-0.069	4.245	0.01	0.007	0	40	36.5	56.3	127	118	0	34	33
2015	7	6	16	44	8	0.771	-0.105	4.245	0.01	0.007	0	39.1	36.1	56.3	125	117	0	34	33
2015	7	6	16	54	8	0.719	-0.085	4.245	0.01	0.007	0	40	36.5	57.2	127	118	0	34	33
2015	7	6	17	4	8	0.784	-0.066	4.249	0.013	0.01	0	39.6	36.1	70.5	126	117	0	34	33
2015	7	6	17	14	8	0.771	-0.056	4.249	0.01	0.007	0	39.6	36.1	71	126	117	0	34	33
2015	7	6	17	24	8	0.745	-0.118	4.249	0.013	0.01	0	39.6	36.1	72.2	126	117	0	34	33
2015	7	6	17	34	8	0.764	-0.102	4.249	0.01	0.007	0	39.6	36.5	72.7	126	117	0	34	32
2015	7	6	17	44	8	0.781	-0.102	4.249	0.01	0.007	0	40	35.7	71.8	127	117	0	34	34
2015	7	6	17	54	8	0.82	-0.079	4.249	0.01	0.007	0	40	36.1	72.2	126	117	0	33	33
2015	7	6	18	4	8	0.764	-0.059	4.249	0.013	0.01	0	40	37	71.8	127	119	0	34	33
2015	7	6	18	14	8	0.774	-0.092	4.249	0.01	0.007	0	40	36.5	71.4	127	118	0	34	33
2015	7	6	18	24	8	0.778	-0.105	4.252	0.01	0.007	0	40.4	37.4	69.7	128	119	0	34	32
2015	7	6	18	34	8	0.797	-0.082	4.252	0.016	0.013	0	40.4	37	66.2	127	119	0	33	33
2015	7	6	18	44	8	0.758	-0.082	4.252	0.013	0.01	0	40.4	37	58.5	128	119	0	34	33
2015	7	6	18	54	8	0.755	-0.085	4.252	0.013	0.01	0	40	36.5	65.4	127	118	0	34	33
2015	7	6	19	4	8	0.778	-0.105	4.252	0.01	0.007	0	40	36.5	70.5	127	118	0	34	33
2015	7	6	19	14	8	0.755	-0.059	4.252	0.01	0.007	0	40	37.4	70.5	128	119	0	35	32
2015	7	6	19	24	8	0.738	-0.069	4.252	0.01	0.007	0	40.4	37.4	70.5	128	120	0	34	33
2015	7	6	19	34	8	0.774	-0.069	4.255	0.01	0.007	0	40.4	37.4	70.5	128	120	0	34	33
2015	7	6	19	44	8	0.771	-0.072	4.255	0.013	0.01	0	40.4	37	70.5	128	119	0	34	33
2015	7	6	19	54	8	0.771	-0.062	4.255	0.01	0.007	0	40.4	37.8	70.5	128	120	0	34	32
2015	7	6	20	4	8	0.771	-0.082	4.255	0.01	0.007	0	40.4	37	71	128	119	0	34	33
2015	7	6	20	14	8	0.791	-0.098	4.255	0.01	0.007	0	40.4	37.4	70.1	128	119	0	34	32
2015	7	6	20	24	8	0.748	-0.066	4.255	0.01	0.007	0	40.9	37.4	70.1	129	120	0	34	33
2015	7	6	20	34	8	0.778	-0.089	4.259	0.01	0.007	0	40.9	37	63.2	129	120	0	34	34
2015	7	6	20	44	8	0.771	-0.059	4.259	0.01	0.007	0	43	40.4	65.4	134	126	0	34	32
2015	7	6	20	54	8	0.771	-0.072	4.259	0.01	0.007	0	43	39.6	67.1	134	125	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	6	21	4	8	0.778	-0.056	4.259	0.01	0.007	0	42.1	39.1	65.4	132	124	0	34	33
2015	7	6	21	14	8	0.738	-0.066	4.259	0.01	0.007	0	43	40	66.2	134	126	0	34	33
2015	7	6	21	24	8	0.764	-0.069	4.259	0.013	0.01	0	42.6	39.1	66.7	133	124	0	34	33
2015	7	6	21	34	8	0.758	-0.059	4.262	0.01	0.007	0	41.7	38.7	67.9	131	122	0	34	32
2015	7	6	21	44	8	0.764	-0.075	4.262	0.01	0.007	0	42.1	38.3	64.5	131	122	0	33	33
2015	7	6	21	54	8	0.761	-0.062	4.265	0.013	0.01	0	42.1	38.7	57.2	132	123	0	34	33
2015	7	6	22	4	8	0.801	-0.072	4.262	0.01	0.007	0	42.6	39.6	62.4	133	124	0	34	32
2015	7	6	22	14	8	0.787	-0.079	4.262	0.01	0.007	0	42.6	39.6	64.5	133	124	0	34	32
2015	7	6	22	24	8	0.755	-0.072	4.265	0.01	0.007	0	42.6	40	62.4	133	125	0	34	32
2015	7	6	22	34	8	0.751	-0.112	4.265	0.01	0.007	0	42.1	39.1	62.4	132	124	0	34	33
2015	7	6	22	44	8	0.771	-0.043	4.268	0.01	0.007	0	42.1	39.1	59.8	132	124	0	34	33
2015	7	6	22	54	8	0.755	-0.043	4.272	0.01	0.007	0	42.1	39.6	59.8	132	124	0	34	32
2015	7	6	23	4	8	0.764	-0.092	4.272	0.01	0.007	0	42.6	39.6	58.9	133	124	0	34	32
2015	7	6	23	14	8	0.735	-0.072	4.275	0.01	0.007	0	42.1	39.1	63.2	132	124	0	34	33
2015	7	6	23	24	8	0.784	-0.092	4.275	0.01	0.007	0	41.3	38.7	58.9	131	123	0	35	33
2015	7	6	23	34	8	0.814	-0.115	4.272	0.013	0.01	0	44.3	40.9	57.6	137	128	0	34	33
2015	7	6	23	44	8	0.758	-0.066	4.278	0.01	0.007	0	43.4	40	56.8	135	126	0	34	33
2015	7	6	23	54	8	0.728	-0.095	4.278	0.01	0.007	0	43	40	55	134	125	0	34	32
2015	7	7	0	4	8	0.814	-0.092	4.278	0.01	0.007	0	42.1	38.7	64.1	132	123	0	34	33
2015	7	7	0	14	8	0.804	-0.075	4.278	0.01	0.007	0	42.1	38.7	63.2	132	123	0	34	33
2015	7	7	0	24	8	0.758	-0.059	4.281	0.013	0.01	0	41.7	38.7	64.1	131	123	0	34	33
2015	7	7	0	34	8	0.791	-0.069	4.281	0.01	0.007	0	42.1	38.3	64.5	131	122	0	33	33
2015	7	7	0	44	8	0.781	-0.069	4.281	0.013	0.01	0	41.7	38.3	65.8	131	122	0	34	33
2015	7	7	0	54	8	0.787	-0.066	4.281	0.016	0.013	0	41.3	37.8	64.9	130	121	0	34	33
2015	7	7	1	4	8	0.764	-0.069	4.281	0.01	0.007	0	41.7	38.3	65.4	130	122	0	33	33
2015	7	7	1	14	8	0.778	-0.112	4.281	0.013	0.01	0	41.3	37.8	66.7	130	121	0	34	33
2015	7	7	1	24	8	0.751	-0.102	4.285	0.01	0.007	0	41.3	37.8	63.6	129	120	0	33	32
2015	7	7	1	34	8	0.755	-0.095	4.285	0.01	0.007	0	42.1	38.7	69.7	132	123	0	34	33
2015	7	7	1	44	8	0.791	-0.098	4.285	0.01	0.007	0	41.3	37.8	66.2	130	121	0	34	33
2015	7	7	1	54	8	0.774	-0.102	4.285	0.01	0.007	0	42.1	38.7	67.5	131	122	0	33	32
2015	7	7	2	4	8	0.784	-0.056	4.285	0.01	0.007	0	41.3	37.8	67.9	130	122	0	34	34
2015	7	7	2	14	8	0.801	-0.089	4.285	0.01	0.007	0	41.7	38.7	69.7	131	122	0	34	32
2015	7	7	2	24	8	0.774	-0.075	4.285	0.013	0.01	0	41.3	38.3	69.7	130	122	0	34	33
2015	7	7	2	34	8	0.758	-0.075	4.288	0.013	0.01	0	41.3	37.8	71.8	130	121	0	34	33
2015	7	7	2	44	8	0.781	-0.092	4.288	0.01	0.007	0	40.9	37.8	70.1	129	121	0	34	33
2015	7	7	2	54	8	0.768	-0.098	4.288	0.01	0.007	0	40.9	37.4	71	129	120	0	34	33
2015	7	7	3	4	8	0.787	-0.062	4.288	0.01	0.007	0	41.7	37.8	71.4	130	121	0	33	33
2015	7	7	3	14	8	0.787	-0.118	4.288	0.013	0.01	0	40.9	38.3	71.4	129	121	0	34	32
2015	7	7	3	24	8	0.781	-0.082	4.288	0.013	0.01	0	41.3	38.3	70.5	129	121	0	33	32
2015	7	7	3	34	8	0.764	-0.082	4.288	0.01	0.007	0	40.9	37.8	71.4	129	121	0	34	33
2015	7	7	3	44	8	0.81	-0.095	4.288	0.01	0.007	0	40.4	37.4	71	128	120	0	34	33
2015	7	7	3	54	8	0.728	-0.082	4.288	0.01	0.007	0	40.4	37.4	71.8	128	120	0	34	33
2015	7	7	4	4	8	0.764	-0.052	4.288	0.016	0.013	0	40.9	37.8	71	129	121	0	34	33
2015	7	7	4	14	8	0.781	-0.059	4.288	0.01	0.007	0	40.9	37.4	71.4	129	120	0	34	33
2015	7	7	4	24	8	0.784	-0.082	4.288	0.01	0.007	0	40.4	37.4	71	128	120	0	34	33
2015	7	7	4	34	8	0.768	-0.082	4.288	0.01	0.007	0	40.4	37	71	128	119	0	34	33
2015	7	7	4	44	8	0.791	-0.092	4.288	0.01	0.007	0	40.4	37	71	128	119	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	7	4	54	8	0.774	-0.069	4.288	0.013	0.01	0	40.4	37.4	70.1	129	120	0	35	33
2015	7	7	5	4	8	0.794	-0.089	4.288	0.01	0.007	0	40.9	37.8	70.5	129	120	0	34	32
2015	7	7	5	14	8	0.774	-0.092	4.291	0.01	0.007	0	40.9	37.4	70.1	129	120	0	34	33
2015	7	7	5	24	8	0.794	-0.079	4.291	0.013	0.01	0	40.4	37.8	70.1	128	120	0	34	32
2015	7	7	5	34	8	0.768	-0.082	4.291	0.01	0.007	0	40.4	37.4	70.5	128	120	0	34	33
2015	7	7	5	44	8	0.794	-0.062	4.291	0.01	0.007	0	40.9	37.4	70.5	129	120	0	34	33
2015	7	7	5	54	8	0.784	-0.082	4.291	0.01	0.007	0	40.4	37	70.1	128	119	0	34	33
2015	7	7	6	4	8	0.801	-0.062	4.291	0.013	0.01	0	40.4	37.4	70.1	128	119	0	34	32
2015	7	7	6	14	8	0.778	-0.072	4.291	0.01	0.007	0	39.6	37	70.5	127	118	0	35	32
2015	7	7	6	24	8	0.781	-0.082	4.291	0.016	0.013	0	39.1	36.5	70.1	126	118	0	35	33
2015	7	7	6	34	8	0.794	-0.095	4.291	0.01	0.007	0	39.6	36.5	69.7	126	118	0	34	33
2015	7	7	6	44	8	0.751	-0.059	4.295	0.01	0.007	0	39.6	37	69.2	127	118	0	35	32
2015	7	7	6	54	8	0.784	-0.062	4.295	0.01	0.007	0	39.1	36.1	69.7	125	117	0	34	33
2015	7	7	7	4	8	0.817	-0.089	4.295	0.013	0.01	0	38.7	35.7	68.8	125	116	0	35	33
2015	7	7	7	14	8	0.807	-0.062	4.295	0.013	0.01	0	39.1	35.7	69.2	124	116	0	33	33
2015	7	7	7	24	8	0.797	-0.075	4.295	0.013	0.01	0	38.7	35.7	68.8	124	116	0	34	33
2015	7	7	7	34	8	0.771	-0.082	4.295	0.01	0.007	0	38.7	35.7	68.8	124	116	0	34	33
2015	7	7	7	44	8	0.768	-0.082	4.295	0.01	0.007	0	39.1	35.7	69.2	125	116	0	34	33
2015	7	7	7	54	8	0.755	-0.072	4.295	0.01	0.007	0	39.1	35.7	68.4	125	116	0	34	33
2015	7	7	8	4	8	0.764	-0.092	4.295	0.01	0.007	0	39.1	35.7	68.8	125	116	0	34	33
2015	7	7	8	14	8	0.784	-0.082	4.295	0.01	0.007	0	38.7	35.7	66.7	124	116	0	34	33
2015	7	7	8	24	8	0.781	-0.075	4.298	0.016	0.013	0	39.1	36.1	67.1	125	117	0	34	33
2015	7	7	8	34	8	0.801	-0.069	4.295	0.01	0.007	0	39.1	36.1	65.8	125	117	0	34	33
2015	7	7	8	44	8	0.801	-0.082	4.295	0.01	0.007	0	39.1	36.1	66.7	125	117	0	34	33
2015	7	7	8	54	8	0.787	-0.072	4.298	0.01	0.007	0	40	36.5	68.4	127	118	0	34	33
2015	7	7	9	4	8	0.774	-0.098	4.298	0.01	0.007	0	39.6	37	67.9	126	118	0	34	32
2015	7	7	9	14	8	0.751	-0.085	4.298	0.01	0.007	0	40	36.1	66.7	127	118	0	34	34
2015	7	7	9	24	8	0.804	-0.105	4.298	0.01	0.007	0	39.6	36.5	66.2	126	118	0	34	33
2015	7	7	9	34	8	0.797	-0.112	4.298	0.01	0.007	0	39.6	36.5	66.7	126	118	0	34	33
2015	7	7	9	44	8	0.787	-0.118	4.298	0.01	0.007	0	38.7	35.7	66.7	124	116	0	34	33
2015	7	7	9	54	8	0.817	-0.125	4.298	0.01	0.007	0	38.7	35.7	67.1	124	116	0	34	33
2015	7	7	10	4	8	0.797	-0.125	4.298	0.013	0.01	0	40	37	64.5	126	118	0	33	32
2015	7	7	10	14	8	0.778	-0.148	4.298	0.013	0.01	0	39.1	35.7	62.4	125	116	0	34	33
2015	7	7	10	24	8	0.781	-0.138	4.298	0.01	0.007	0	39.6	36.1	64.1	126	117	0	34	33
2015	7	7	10	34	8	0.768	-0.131	4.298	0.01	0.007	0	40	37	61.1	127	118	0	34	32
2015	7	7	10	44	8	0.791	-0.141	4.298	0.01	0.007	0	39.6	36.1	68.8	126	117	0	34	33
2015	7	7	10	54	8	0.804	-0.098	4.298	0.01	0.007	0	40	36.5	56.3	127	119	0	34	34
2015	7	7	11	4	8	0.778	-0.144	4.298	0.01	0.007	0	40	36.5	67.1	127	118	0	34	33
2015	7	7	11	14	8	0.797	-0.131	4.298	0.01	0.007	0	40.4	37	65.4	128	119	0	34	33
2015	7	7	11	24	8	0.794	-0.112	4.301	0.01	0.007	0	40	37	54.6	127	119	0	34	33
2015	7	7	11	34	8	0.82	-0.079	4.304	0.01	0.007	0	41.3	37.8	52	130	121	0	34	33
2015	7	7	11	44	8	0.781	-0.092	4.301	0.01	0.007	0	40.9	37.4	50.3	129	120	0	34	33
2015	7	7	11	54	8	0.758	-0.102	4.301	0.013	0.01	0	41.7	38.3	49	131	122	0	34	33
2015	7	7	12	4	8	0.784	-0.131	4.301	0.013	0.01	0	42.1	38.7	50.7	131	123	0	33	33
2015	7	7	12	14	8	0.761	-0.135	4.301	0.01	0.007	0	41.7	38.3	46.9	131	122	0	34	33
2015	7	7	12	24	8	0.771	-0.066	4.308	0.01	0.007	0	42.1	39.1	50.3	132	123	0	34	32
2015	7	7	12	34	8	0.804	-0.089	4.301	0.013	0.01	0	43	39.6	51.6	133	125	0	33	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	7	12	44	8	0.768	-0.085	4.304	0.01	0.007	0	41.7	39.1	49.9	132	124	0	35	33
2015	7	7	12	54	8	0.804	-0.095	4.304	0.01	0.007	0	43.4	40.4	49.5	135	126	0	34	32
2015	7	7	13	4	8	0.771	-0.066	4.304	0.01	0.007	0	42.6	39.6	47.7	133	124	0	34	32
2015	7	7	13	14	8	0.768	-0.144	4.298	0.01	0.007	0	42.6	39.1	48.2	133	124	0	34	33
2015	7	7	13	24	8	0.814	-0.102	4.301	0.01	0.007	0	42.1	38.7	52	132	123	0	34	33
2015	7	7	13	34	8	0.781	-0.085	4.304	0.01	0.007	0	42.1	38.7	51.2	132	123	0	34	33
2015	7	7	13	44	8	0.778	-0.095	4.301	0.013	0.01	0	42.6	38.7	50.7	132	124	0	33	34
2015	7	7	13	54	8	0.784	-0.118	4.301	0.013	0.01	0	42.1	39.1	49.5	132	124	0	34	33
2015	7	7	14	4	8	0.791	-0.092	4.301	0.01	0.007	0	42.6	39.1	51.6	132	124	0	33	33
2015	7	7	14	14	8	0.804	-0.118	4.301	0.01	0.007	0	41.7	38.7	50.7	131	122	0	34	32
2015	7	7	14	24	8	0.768	-0.102	4.301	0.01	0.007	0	41.3	38.7	50.3	130	122	0	34	32
2015	7	7	14	34	8	0.778	-0.085	4.301	0.01	0.007	0	41.3	38.3	51.2	130	122	0	34	33
2015	7	7	14	44	8	0.764	-0.069	4.301	0.01	0.007	0	41.7	38.7	50.3	131	123	0	34	33
2015	7	7	14	54	8	0.781	-0.075	4.298	0.01	0.007	0	42.1	39.6	50.3	132	124	0	34	32
2015	7	7	15	4	8	0.801	-0.095	4.301	0.01	0.007	0	42.1	38.3	50.7	132	123	0	34	34
2015	7	7	15	14	8	0.781	-0.075	4.301	0.013	0.01	0	41.7	39.6	49.5	131	123	0	34	31
2015	7	7	15	24	8	0.791	-0.108	4.301	0.01	0.007	0	41.3	38.3	51.2	130	122	0	34	33
2015	7	7	15	34	8	0.758	-0.102	4.301	0.01	0.007	0	42.1	38.7	50.7	131	123	0	33	33
2015	7	7	15	44	8	0.778	-0.072	4.308	0.01	0.007	0	42.1	39.1	50.3	132	124	0	34	33
2015	7	7	15	54	8	0.787	-0.075	4.301	0.01	0.007	0	41.7	39.1	49.9	132	124	0	35	33
2015	7	7	16	4	8	0.807	-0.085	4.301	0.01	0.007	0	41.7	38.3	49.9	131	122	0	34	33
2015	7	7	16	14	8	0.787	-0.095	4.301	0.013	0.01	0	41.7	38.7	48.6	131	123	0	34	33
2015	7	7	16	24	8	0.817	-0.072	4.301	0.01	0.007	0	42.1	39.1	51.2	132	124	0	34	33
2015	7	7	16	34	8	0.764	-0.098	4.301	0.013	0.01	0	42.1	39.1	50.3	132	124	0	34	33
2015	7	7	16	44	8	0.801	-0.115	4.308	0.013	0.01	0	41.7	38.7	49.5	131	123	0	34	33
2015	7	7	16	54	8	0.774	-0.085	4.298	0.01	0.007	0	41.7	38.7	51.6	131	123	0	34	33
2015	7	7	17	4	8	0.774	-0.043	4.301	0.01	0.007	0	42.1	39.1	52.5	132	124	0	34	33
2015	7	7	17	14	8	0.768	-0.085	4.301	0.01	0.007	0	42.1	38.7	49.9	131	123	0	33	33
2015	7	7	17	24	8	0.774	-0.108	4.301	0.01	0.007	0	41.3	38.3	52.5	130	122	0	34	33
2015	7	7	17	34	8	0.804	-0.098	4.304	0.013	0.01	0	41.3	37.8	51.2	130	121	0	34	33
2015	7	7	17	44	8	0.784	-0.128	4.298	0.01	0.007	0	41.3	38.3	47.7	130	122	0	34	33
2015	7	7	17	54	8	0.771	-0.105	4.298	0.01	0.007	0	40.9	37.8	48.6	129	121	0	34	33
2015	7	7	18	4	8	0.807	-0.085	4.301	0.01	0.007	0	41.3	38.3	53.8	130	122	0	34	33
2015	7	7	18	14	8	0.784	-0.098	4.298	0.016	0.013	0	40.9	37.8	51.6	129	121	0	34	33
2015	7	7	18	24	8	0.774	-0.075	4.298	0.013	0.01	0	40.4	37.8	52.5	128	120	0	34	32
2015	7	7	18	34	8	0.768	-0.098	4.301	0.01	0.007	0	41.3	37.8	50.7	129	121	0	33	33
2015	7	7	18	44	8	0.784	-0.082	4.301	0.01	0.007	0	41.3	38.3	49.5	129	121	0	33	32
2015	7	7	18	54	8	0.82	-0.089	4.301	0.01	0.007	0	41.3	37.8	50.7	130	121	0	34	33
2015	7	7	19	4	8	0.768	-0.108	4.298	0.01	0.007	0	40.9	38.3	55	129	121	0	34	32
2015	7	7	19	14	8	0.801	-0.056	4.298	0.01	0.007	0	41.3	38.3	58	130	122	0	34	33
2015	7	7	19	24	8	0.791	-0.108	4.298	0.01	0.007	0	41.3	38.3	66.2	130	121	0	34	32
2015	7	7	19	34	8	0.801	-0.105	4.298	0.01	0.007	0	41.7	38.3	65.8	131	122	0	34	33
2015	7	7	19	44	8	0.794	-0.046	4.301	0.016	0.013	0	41.7	38.3	55.5	131	122	0	34	33
2015	7	7	19	54	8	0.771	-0.066	4.308	0.01	0.007	0	42.1	39.6	51.2	133	125	0	35	33
2015	7	7	20	4	8	0.771	-0.082	4.304	0.01	0.007	0	43.9	40.9	53.3	136	128	0	34	33
2015	7	7	20	14	8	0.764	-0.069	4.301	0.013	0.01	0	43.9	40.9	58.9	136	128	0	34	33
2015	7	7	20	24	8	0.761	-0.105	4.301	0.01	0.007	0	43.4	40.4	60.6	135	127	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	7	20	34	8	0.755	-0.069	4.304	0.01	0.007	0	43.4	40	53.8	135	127	0	34	34
2015	7	7	20	44	8	0.764	-0.102	4.304	0.01	0.007	0	43	40	55.5	134	126	0	34	33
2015	7	7	20	54	8	0.814	-0.092	4.308	0.01	0.007	0	43	40	54.2	134	126	0	34	33
2015	7	7	21	4	8	0.761	-0.049	4.304	0.01	0.007	0	43	40	59.3	134	126	0	34	33
2015	7	7	21	14	8	0.781	-0.075	4.304	0.01	0.007	0	43.4	40.4	59.3	135	126	0	34	32
2015	7	7	21	24	8	0.804	-0.075	4.304	0.01	0.007	0	43.4	40	63.6	134	126	0	33	33
2015	7	7	21	34	8	0.748	-0.049	4.304	0.01	0.007	0	43	40	64.9	134	125	0	34	32
2015	7	7	21	44	8	0.774	-0.082	4.308	0.013	0.01	0	43	39.6	63.6	134	125	0	34	33
2015	7	7	21	54	8	0.755	-0.085	4.308	0.01	0.007	0	42.6	39.6	62.4	133	125	0	34	33
2015	7	7	22	4	8	0.801	-0.112	4.308	0.01	0.007	0	43	39.6	63.6	133	125	0	33	33
2015	7	7	22	14	8	0.784	-0.056	4.311	0.01	0.007	0	42.6	39.6	61.5	133	125	0	34	33
2015	7	7	22	24	8	0.791	-0.046	4.314	0.01	0.007	0	42.6	39.1	56.3	133	125	0	34	34
2015	7	7	22	34	8	0.817	-0.082	4.314	0.01	0.007	0	42.6	39.6	55.5	133	125	0	34	33
2015	7	7	22	44	8	0.807	-0.049	4.314	0.013	0.01	0	42.6	39.6	52	133	125	0	34	33
2015	7	7	22	54	8	0.781	-0.066	4.318	0.01	0.007	0	43	40	51.6	134	125	0	34	32
2015	7	7	23	4	8	0.774	-0.075	4.318	0.01	0.007	0	43	40	52	134	126	0	34	33
2015	7	7	23	14	8	0.784	-0.062	4.318	0.01	0.007	0	43	40.4	52	134	126	0	34	32
2015	7	7	23	24	8	0.778	-0.066	4.318	0.013	0.01	0	43	39.6	52.9	134	126	0	34	34
2015	7	7	23	34	8	0.774	-0.085	4.321	0.01	0.007	0	42.6	39.1	53.8	133	125	0	34	34
2015	7	7	23	44	8	0.778	-0.072	4.318	0.01	0.007	0	43	39.6	53.8	134	125	0	34	33
2015	7	7	23	54	8	0.764	-0.075	4.318	0.01	0.007	0	42.6	39.6	56.8	134	125	0	35	33
2015	7	8	0	4	8	0.787	-0.085	4.321	0.01	0.007	0	42.6	39.6	54.2	133	125	0	34	33
2015	7	8	0	14	8	0.784	-0.095	4.318	0.01	0.007	0	44.3	41.7	52.5	137	129	0	34	32
2015	7	8	0	24	8	0.758	-0.075	4.321	0.01	0.007	0	43.4	40.9	53.3	135	127	0	34	32
2015	7	8	0	34	8	0.804	-0.062	4.321	0.01	0.007	0	43	39.6	55	134	125	0	34	33
2015	7	8	0	44	8	0.791	-0.069	4.321	0.01	0.007	0	42.6	39.1	53.8	133	124	0	34	33
2015	7	8	0	54	8	0.745	-0.079	4.321	0.01	0.007	0	42.6	39.6	52.9	132	124	0	33	32
2015	7	8	1	4	8	0.787	-0.082	4.324	0.01	0.007	0	42.6	39.6	53.8	133	125	0	34	33
2015	7	8	1	14	8	0.751	-0.046	4.321	0.013	0.01	0	42.1	39.6	53.8	132	124	0	34	32
2015	7	8	1	24	8	0.768	-0.03	4.324	0.01	0.007	0	42.1	39.1	54.6	132	124	0	34	33
2015	7	8	1	34	8	0.837	-0.098	4.324	0.01	0.007	0	42.1	39.1	53.3	132	123	0	34	32
2015	7	8	1	44	8	0.797	-0.062	4.324	0.01	0.007	0	42.1	39.1	55	132	124	0	34	33
2015	7	8	1	54	8	0.784	-0.082	4.324	0.01	0.007	0	41.7	38.7	62.4	131	123	0	34	33
2015	7	8	2	4	8	0.804	-0.082	4.324	0.013	0.01	0	41.7	39.1	56.3	131	123	0	34	32
2015	7	8	2	14	8	0.804	-0.049	4.324	0.01	0.007	0	42.1	39.6	63.2	132	124	0	34	32
2015	7	8	2	24	8	0.774	-0.059	4.324	0.013	0.01	0	41.7	38.7	70.1	131	123	0	34	33
2015	7	8	2	34	8	0.741	-0.049	4.324	0.01	0.007	0	41.7	38.7	71	131	123	0	34	33
2015	7	8	2	44	8	0.764	-0.075	4.324	0.013	0.01	0	41.3	38.7	70.5	131	123	0	35	33
2015	7	8	2	54	8	0.82	-0.049	4.324	0.01	0.007	0	42.6	39.1	71	133	124	0	34	33
2015	7	8	3	4	8	0.758	-0.075	4.324	0.01	0.007	0	43	40	70.1	134	126	0	34	33
2015	7	8	3	14	8	0.784	-0.112	4.324	0.01	0.007	0	42.1	39.1	71.4	132	124	0	34	33
2015	7	8	3	24	8	0.846	-0.075	4.327	0.01	0.007	0	42.1	39.1	71	132	124	0	34	33
2015	7	8	3	34	8	0.794	-0.095	4.327	0.013	0.01	0	42.1	39.1	71	132	124	0	34	33
2015	7	8	3	44	8	0.801	-0.066	4.327	0.01	0.007	0	42.1	39.1	71.4	132	124	0	34	33
2015	7	8	3	54	8	0.771	-0.082	4.327	0.01	0.007	0	42.1	39.1	70.5	132	124	0	34	33
2015	7	8	4	4	8	0.801	-0.072	4.327	0.01	0.007	0	42.1	39.6	69.2	132	124	0	34	32
2015	7	8	4	14	8	0.778	-0.062	4.327	0.01	0.007	0	41.7	39.1	70.5	131	123	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	8	4	24	8	0.791	-0.098	4.327	0.01	0.007	0	42.6	39.6	70.5	132	124	0	33	32
2015	7	8	4	34	8	0.797	-0.033	4.327	0.01	0.007	0	42.1	39.1	70.5	132	124	0	34	33
2015	7	8	4	44	8	0.81	-0.082	4.327	0.01	0.007	0	41.7	38.7	70.5	131	123	0	34	33
2015	7	8	4	54	8	0.784	-0.056	4.327	0.016	0.013	0	42.1	39.6	70.5	132	124	0	34	32
2015	7	8	5	4	8	0.807	-0.102	4.327	0.01	0.007	0	42.1	39.6	70.1	132	124	0	34	32
2015	7	8	5	14	8	0.768	-0.043	4.327	0.013	0.01	0	42.6	39.6	71.4	133	125	0	34	33
2015	7	8	5	24	8	0.771	-0.098	4.327	0.01	0.007	0	42.6	39.1	71	132	124	0	33	33
2015	7	8	5	34	8	0.787	-0.105	4.327	0.01	0.007	0	41.7	39.1	70.5	132	124	0	35	33
2015	7	8	5	44	8	0.768	-0.072	4.327	0.01	0.007	0	41.7	38.7	69.7	131	123	0	34	33
2015	7	8	5	54	8	0.781	-0.085	4.327	0.01	0.007	0	42.1	39.1	70.5	132	124	0	34	33
2015	7	8	6	4	8	0.791	-0.085	4.327	0.01	0.007	0	42.1	38.7	70.1	132	123	0	34	33
2015	7	8	6	14	8	0.804	-0.056	4.327	0.01	0.007	0	42.1	39.6	69.7	132	124	0	34	32
2015	7	8	6	24	8	0.771	-0.095	4.327	0.01	0.007	0	41.7	38.7	61.1	131	123	0	34	33
2015	7	8	6	34	8	0.791	-0.082	4.327	0.01	0.007	0	42.1	38.7	70.1	132	123	0	34	33
2015	7	8	6	44	8	0.787	-0.072	4.327	0.013	0.01	0	43	39.6	69.2	134	125	0	34	33
2015	7	8	6	54	8	0.791	-0.102	4.327	0.01	0.007	0	42.1	39.6	69.7	132	124	0	34	32
2015	7	8	7	4	8	0.768	-0.082	4.327	0.01	0.007	0	42.6	39.1	69.2	132	124	0	33	33
2015	7	8	7	14	8	0.787	-0.062	4.331	0.01	0.007	0	43	39.6	69.2	133	125	0	33	33
2015	7	8	7	24	8	0.804	-0.072	4.331	0.01	0.007	0	42.1	39.6	68.8	132	125	0	34	33
2015	7	8	7	34	8	0.797	-0.092	4.331	0.013	0.01	0	43	40	68.4	134	126	0	34	33
2015	7	8	7	44	8	0.827	-0.098	4.331	0.01	0.007	0	43	40.4	67.5	134	126	0	34	32
2015	7	8	7	54	8	0.794	-0.079	4.331	0.01	0.007	0	44.3	41.3	68.8	137	129	0	34	33
2015	7	8	8	4	8	0.801	-0.095	4.331	0.01	0.007	0	42.6	39.6	68.4	133	126	0	34	34
2015	7	8	8	14	8	0.787	-0.112	4.331	0.013	0.01	0	43	40.4	67.9	134	126	0	34	32
2015	7	8	8	24	8	0.81	-0.098	4.331	0.01	0.007	0	43	40	67.1	134	126	0	34	33
2015	7	8	8	34	8	0.784	-0.082	4.331	0.013	0.01	0	43	40	66.7	134	126	0	34	33
2015	7	8	8	44	8	0.768	-0.066	4.331	0.01	0.007	0	43.4	39.6	66.2	134	126	0	33	34
2015	7	8	8	54	8	0.807	-0.092	4.331	0.013	0.01	0	42.1	39.6	62.8	132	124	0	34	32
2015	7	8	9	4	8	0.755	-0.098	4.331	0.013	0.01	0	42.1	39.1	68.8	132	124	0	34	33
2015	7	8	9	14	8	0.797	-0.115	4.331	0.01	0.007	0	42.1	38.7	68.8	132	124	0	34	34
2015	7	8	9	24	8	0.784	-0.135	4.331	0.01	0.007	0	41.7	39.1	67.1	132	123	0	35	32
2015	7	8	9	34	8	0.84	-0.148	4.331	0.01	0.007	0	42.6	39.6	69.2	133	125	0	34	33
2015	7	8	9	44	8	0.82	-0.089	4.331	0.016	0.013	0	42.6	39.6	67.5	133	125	0	34	33
2015	7	8	9	54	8	0.801	-0.108	4.331	0.01	0.007	0	42.6	39.1	63.2	133	124	0	34	33
2015	7	8	10	4	8	0.787	-0.128	4.331	0.01	0.007	0	42.1	39.1	62.8	132	124	0	34	33
2015	7	8	10	14	8	0.801	-0.141	4.331	0.01	0.007	0	41.7	39.1	67.5	131	124	0	34	33
2015	7	8	10	24	8	0.81	-0.118	4.331	0.01	0.007	0	42.1	39.1	59.8	132	124	0	34	33
2015	7	8	10	34	8	0.794	-0.131	4.331	0.01	0.007	0	41.7	39.1	67.5	131	123	0	34	32
2015	7	8	10	44	8	0.814	-0.135	4.331	0.01	0.007	0	41.7	39.1	65.8	131	124	0	34	33
2015	7	8	10	54	8	0.797	-0.174	4.331	0.01	0.007	0	41.3	38.3	62.8	130	122	0	34	33
2015	7	8	11	4	8	0.83	-0.098	4.331	0.01	0.007	0	41.7	38.7	68.4	130	123	0	33	33
2015	7	8	11	14	8	0.82	-0.148	4.331	0.01	0.007	0	40.9	38.3	64.5	129	122	0	34	33
2015	7	8	11	24	8	0.814	-0.157	4.331	0.01	0.007	0	41.3	37.8	64.5	129	121	0	33	33
2015	7	8	11	34	8	0.781	-0.164	4.331	0.01	0.007	0	40.9	37.4	64.5	129	120	0	34	33
2015	7	8	11	44	8	0.794	-0.138	4.331	0.01	0.007	0	41.3	38.3	64.9	130	122	0	34	33
2015	7	8	11	54	8	0.787	-0.105	4.331	0.013	0.01	0	41.3	38.3	59.8	130	122	0	34	33
2015	7	8	12	4	8	0.804	-0.095	4.334	0.013	0.01	0	41.3	38.3	52.9	130	122	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	8	12	14	8	0.807	-0.102	4.331	0.01	0.007	0	40.9	37.8	53.3	129	121	0	34	33
2015	7	8	12	24	8	0.781	-0.151	4.331	0.013	0.01	0	41.3	38.3	62.4	129	121	0	33	32
2015	7	8	12	34	8	0.784	-0.118	4.331	0.01	0.007	0	41.3	38.3	54.2	130	122	0	34	33
2015	7	8	12	44	8	0.801	-0.118	4.334	0.01	0.007	0	40.9	37.8	52.5	129	121	0	34	33
2015	7	8	12	54	8	0.771	-0.164	4.334	0.01	0.007	0	41.3	38.3	49.5	130	122	0	34	33
2015	7	8	13	4	8	0.787	-0.062	4.331	0.013	0.01	0	41.7	38.3	50.3	130	122	0	33	33
2015	7	8	13	14	8	0.784	-0.118	4.331	0.01	0.007	0	40.9	38.3	50.7	129	122	0	34	33
2015	7	8	13	24	8	0.807	-0.174	4.331	0.01	0.007	0	41.3	37.8	50.3	130	122	0	34	34
2015	7	8	13	34	8	0.771	-0.089	4.331	0.013	0.01	0	41.3	38.3	50.3	130	122	0	34	33
2015	7	8	13	44	8	0.778	-0.079	4.331	0.01	0.007	0	41.3	39.1	47.7	131	124	0	35	33
2015	7	8	13	54	8	0.797	-0.108	4.331	0.01	0.007	0	41.3	38.7	49	130	123	0	34	33
2015	7	8	14	4	8	0.751	-0.135	4.331	0.013	0.01	0	41.7	38.7	49.9	131	123	0	34	33
2015	7	8	14	14	8	0.801	-0.118	4.331	0.01	0.007	0	41.3	38.7	50.7	131	123	0	35	33
2015	7	8	14	24	8	0.751	-0.118	4.327	0.01	0.007	0	42.1	39.1	49.5	132	124	0	34	33
2015	7	8	14	34	8	0.804	-0.089	4.331	0.01	0.007	0	41.7	38.7	50.3	131	123	0	34	33
2015	7	8	14	44	8	0.794	-0.089	4.331	0.01	0.007	0	41.3	38.7	52.5	130	123	0	34	33
2015	7	8	14	54	8	0.774	-0.059	4.331	0.01	0.007	0	41.7	38.7	49.9	131	123	0	34	33
2015	7	8	15	4	8	0.801	-0.118	4.331	0.01	0.007	0	41.7	38.7	48.6	131	123	0	34	33
2015	7	8	15	14	8	0.797	-0.125	4.327	0.01	0.007	0	41.3	38.7	46.9	130	122	0	34	32
2015	7	8	15	24	8	0.784	-0.089	4.327	0.01	0.007	0	41.7	38.7	49.5	131	123	0	34	33
2015	7	8	15	34	8	0.774	-0.125	4.327	0.01	0.007	0	41.7	38.3	51.2	131	122	0	34	33
2015	7	8	15	44	8	0.784	-0.075	4.327	0.01	0.007	0	41.7	38.7	50.3	130	123	0	33	33
2015	7	8	15	54	8	0.761	-0.072	4.331	0.016	0.013	0	41.7	39.1	51.6	131	124	0	34	33
2015	7	8	16	4	8	0.748	-0.092	4.334	0.01	0.007	0	42.1	38.7	48.6	131	123	0	33	33
2015	7	8	16	14	8	0.814	-0.092	4.327	0.01	0.007	0	41.7	39.6	50.7	131	124	0	34	32
2015	7	8	16	24	8	0.797	-0.108	4.331	0.01	0.007	0	41.7	38.7	50.3	131	123	0	34	33
2015	7	8	16	34	8	0.778	-0.079	4.327	0.01	0.007	0	42.1	39.1	51.6	132	124	0	34	33
2015	7	8	16	44	8	0.817	-0.072	4.327	0.01	0.007	0	41.7	38.7	50.7	131	123	0	34	33
2015	7	8	16	54	8	0.787	-0.062	4.331	0.01	0.007	0	41.3	38.7	50.7	131	123	0	35	33
2015	7	8	17	4	8	0.797	-0.098	4.327	0.01	0.007	0	41.7	38.7	52.9	131	123	0	34	33
2015	7	8	17	14	8	0.81	-0.118	4.327	0.01	0.007	0	40.9	37.8	48.6	129	121	0	34	33
2015	7	8	17	24	8	0.794	-0.118	4.324	0.01	0.007	0	40.9	38.3	53.3	130	122	0	35	33
2015	7	8	17	34	8	0.784	-0.079	4.327	0.01	0.007	0	41.3	38.3	51.6	130	122	0	34	33
2015	7	8	17	44	8	0.81	-0.079	4.327	0.01	0.007	0	41.7	39.1	50.7	131	124	0	34	33
2015	7	8	17	54	8	0.778	-0.062	4.327	0.01	0.007	0	41.3	37.8	52	130	122	0	34	34
2015	7	8	18	4	8	0.781	-0.075	4.327	0.01	0.007	0	41.3	38.7	52.5	130	122	0	34	32
2015	7	8	18	14	8	0.82	-0.095	4.327	0.01	0.007	0	41.3	38.3	50.3	130	122	0	34	33
2015	7	8	18	24	8	0.807	-0.118	4.327	0.01	0.007	0	41.3	38.7	47.7	130	122	0	34	32
2015	7	8	18	34	8	0.787	-0.079	4.327	0.01	0.007	0	41.3	38.3	50.7	130	122	0	34	33
2015	7	8	18	44	8	0.833	-0.072	4.327	0.01	0.007	0	41.7	38.3	52.5	131	122	0	34	33
2015	7	8	18	54	8	0.778	-0.089	4.327	0.01	0.007	0	41.7	38.7	63.6	131	123	0	34	33
2015	7	8	19	4	8	0.797	-0.085	4.327	0.01	0.007	0	42.1	39.1	66.7	132	124	0	34	33
2015	7	8	19	14	8	0.794	-0.066	4.331	0.01	0.007	0	42.6	39.1	52.9	133	124	0	34	33
2015	7	8	19	24	8	0.738	-0.049	4.331	0.013	0.01	0	43.4	40.9	51.6	135	127	0	34	32
2015	7	8	19	34	8	0.797	-0.075	4.331	0.01	0.007	0	44.3	42.1	52.5	137	130	0	34	32
2015	7	8	19	44	8	0.787	-0.066	4.327	0.01	0.007	0	44.3	40.9	52	137	128	0	34	33
2015	7	8	19	54	8	0.778	-0.079	4.331	0.01	0.007	0	44.3	41.7	52.9	137	129	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	8	20	4	8	0.755	-0.075	4.334	0.01	0.007	0	43.9	40.9	51.2	136	128	0	34	33
2015	7	8	20	14	8	0.761	-0.033	4.334	0.01	0.007	0	44.3	41.7	49.5	137	129	0	34	32
2015	7	8	20	24	8	0.787	-0.046	4.331	0.01	0.007	0	44.7	42.1	51.6	138	131	0	34	33
2015	7	8	20	34	8	0.804	-0.039	4.331	0.01	0.007	0	44.7	42.1	52	138	130	0	34	32
2015	7	8	20	44	8	0.771	-0.085	4.331	0.01	0.007	0	44.7	41.3	51.6	138	129	0	34	33
2015	7	8	20	54	8	0.755	-0.049	4.331	0.01	0.007	0	45.2	42.1	52.5	139	130	0	34	32
2015	7	8	21	4	8	0.794	-0.095	4.331	0.01	0.007	0	44.3	41.3	52	137	129	0	34	33
2015	7	8	21	14	8	0.784	-0.03	4.331	0.01	0.007	0	44.3	40.9	52.9	136	128	0	33	33
2015	7	8	21	24	8	0.764	-0.082	4.334	0.01	0.007	0	43.9	40.4	52.9	136	127	0	34	33
2015	7	8	21	34	8	0.797	-0.085	4.334	0.013	0.01	0	43.4	40.4	53.8	135	127	0	34	33
2015	7	8	21	44	8	0.787	-0.069	4.331	0.01	0.007	0	43.4	40.4	54.2	135	127	0	34	33
2015	7	8	21	54	8	0.794	-0.066	4.334	0.013	0.01	0	43	40	54.6	134	126	0	34	33
2015	7	8	22	4	8	0.797	-0.052	4.334	0.013	0.01	0	43.4	40	55.5	135	126	0	34	33
2015	7	8	22	14	8	0.755	-0.056	4.334	0.01	0.007	0	43.4	40	54.2	135	126	0	34	33
2015	7	8	22	24	8	0.768	-0.105	4.334	0.01	0.007	0	43	40	55.5	134	126	0	34	33
2015	7	8	22	34	8	0.791	-0.085	4.334	0.013	0.01	0	43	40	54.2	134	126	0	34	33
2015	7	8	22	44	8	0.787	-0.033	4.334	0.01	0.007	0	43.4	40	53.8	135	126	0	34	33
2015	7	8	22	54	8	0.794	-0.072	4.334	0.01	0.007	0	43.9	40.9	52.5	136	128	0	34	33
2015	7	8	23	4	8	0.755	-0.072	4.334	0.01	0.007	0	43.9	40.9	50.7	137	128	0	35	33
2015	7	8	23	14	8	0.745	-0.056	4.337	0.013	0.01	0	46	43	49	141	133	0	34	33
2015	7	8	23	24	8	0.771	-0.049	4.337	0.01	0.007	0	44.7	41.7	52.5	138	130	0	34	33
2015	7	8	23	34	8	0.755	-0.062	4.337	0.01	0.007	0	44.7	41.3	51.6	138	129	0	34	33
2015	7	8	23	44	8	0.771	-0.066	4.337	0.01	0.007	0	44.3	41.7	52	138	130	0	35	33
2015	7	8	23	54	8	0.761	-0.062	4.334	0.013	0.01	0	44.7	41.7	51.2	137	129	0	33	32
2015	7	9	0	4	8	0.771	-0.049	4.337	0.01	0.007	0	44.7	41.3	50.3	138	129	0	34	33
2015	7	9	0	14	8	0.781	-0.049	4.337	0.01	0.007	0	44.7	41.7	51.2	138	130	0	34	33
2015	7	9	0	24	8	0.823	-0.049	4.341	0.013	0.01	0	45.2	41.3	51.2	138	129	0	33	33
2015	7	9	0	34	8	0.741	-0.059	4.337	0.01	0.007	0	45.2	41.7	49.9	139	130	0	34	33
2015	7	9	0	44	8	0.764	-0.069	4.337	0.01	0.007	0	45.2	42.1	49.9	139	131	0	34	33
2015	7	9	0	54	8	0.768	-0.062	4.337	0.01	0.007	0	46	43	49.5	141	133	0	34	33
2015	7	9	1	4	8	0.784	-0.082	4.341	0.01	0.007	0	46	43.4	49.9	142	133	0	35	32
2015	7	9	1	14	8	0.761	-0.056	4.341	0.016	0.013	0	46	43	49	141	133	0	34	33
2015	7	9	1	24	8	0.755	-0.036	4.341	0.01	0.007	0	46	42.6	48.2	141	132	0	34	33
2015	7	9	1	34	8	0.791	-0.062	4.341	0.013	0.01	0	45.2	42.1	51.2	139	131	0	34	33
2015	7	9	1	44	8	0.797	-0.069	4.341	0.01	0.007	0	44.7	42.6	49.9	139	131	0	35	32
2015	7	9	1	54	8	0.755	-0.069	4.337	0.01	0.007	0	44.7	41.3	52.5	138	130	0	34	34
2015	7	9	2	4	8	0.784	-0.056	4.341	0.01	0.007	0	44.7	41.7	52.5	138	130	0	34	33
2015	7	9	2	14	8	0.801	-0.052	4.337	0.01	0.007	0	44.3	41.3	54.2	137	128	0	34	32
2015	7	9	2	24	8	0.784	-0.062	4.337	0.01	0.007	0	44.3	40.9	54.2	137	128	0	34	33
2015	7	9	2	34	8	0.774	-0.043	4.341	0.01	0.007	0	43.9	40.9	53.3	136	128	0	34	33
2015	7	9	2	44	8	0.801	-0.085	4.341	0.01	0.007	0	43.4	40.4	54.2	135	127	0	34	33
2015	7	9	2	54	8	0.797	-0.069	4.337	0.01	0.007	0	43.4	40.9	61.9	135	127	0	34	32
2015	7	9	3	4	8	0.774	-0.066	4.341	0.01	0.007	0	43.4	40	52.9	135	126	0	34	33
2015	7	9	3	14	8	0.784	-0.049	4.341	0.013	0.01	0	43.9	40.4	54.6	135	127	0	33	33
2015	7	9	3	24	8	0.784	-0.082	4.341	0.01	0.007	0	43	40	55	134	126	0	34	33
2015	7	9	3	34	8	0.758	-0.069	4.341	0.01	0.007	0	43	40.4	55.9	134	126	0	34	32
2015	7	9	3	44	8	0.801	-0.102	4.344	0.01	0.007	0	43.4	40	53.3	134	126	0	33	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	9	3	54	8	0.781	-0.089	4.344	0.01	0.007	0	43	40.4	54.2	134	126	0	34	32
2015	7	9	4	4	8	0.771	-0.095	4.344	0.01	0.007	0	43.4	40.4	57.6	135	127	0	34	33
2015	7	9	4	14	8	0.768	-0.069	4.347	0.01	0.007	0	43	40.4	52.5	134	126	0	34	32
2015	7	9	4	24	8	0.784	-0.069	4.344	0.01	0.007	0	43	40.4	59.8	135	127	0	35	33
2015	7	9	4	34	8	0.781	-0.066	4.344	0.01	0.007	0	43	39.6	60.6	134	126	0	34	34
2015	7	9	4	44	8	0.764	-0.052	4.347	0.01	0.007	0	43	40	57.2	134	126	0	34	33
2015	7	9	4	54	8	0.801	-0.095	4.347	0.01	0.007	0	42.6	39.6	64.5	133	125	0	34	33
2015	7	9	5	4	8	0.781	-0.066	4.347	0.01	0.007	0	42.1	40	59.8	133	125	0	35	32
2015	7	9	5	14	8	0.804	-0.062	4.347	0.013	0.01	0	42.1	39.6	67.1	132	124	0	34	32
2015	7	9	5	24	8	0.804	-0.062	4.35	0.01	0.007	0	42.6	39.6	66.7	133	125	0	34	33
2015	7	9	5	34	8	0.814	-0.082	4.35	0.01	0.007	0	42.1	39.1	67.9	132	124	0	34	33
2015	7	9	5	44	8	0.801	-0.092	4.347	0.01	0.007	0	41.7	39.1	67.1	132	124	0	35	33
2015	7	9	5	54	8	0.84	-0.085	4.35	0.01	0.007	0	42.1	39.1	67.1	132	124	0	34	33
2015	7	9	6	4	8	0.794	-0.066	4.35	0.01	0.007	0	41.7	38.7	67.5	132	123	0	35	33
2015	7	9	6	14	8	0.771	-0.082	4.35	0.013	0.01	0	42.1	39.1	68.4	132	124	0	34	33
2015	7	9	6	24	8	0.781	-0.075	4.35	0.01	0.007	0	42.6	39.6	68.4	133	125	0	34	33
2015	7	9	6	34	8	0.771	-0.023	4.35	0.01	0.007	0	42.1	39.1	68.4	132	124	0	34	33
2015	7	9	6	44	8	0.817	-0.062	4.35	0.01	0.007	0	41.7	38.7	67.9	131	123	0	34	33
2015	7	9	6	54	8	0.807	-0.108	4.35	0.01	0.007	0	42.1	38.7	67.9	132	124	0	34	34
2015	7	9	7	4	8	0.807	-0.102	4.35	0.01	0.007	0	42.1	39.6	67.5	132	124	0	34	32
2015	7	9	7	14	8	0.81	-0.072	4.35	0.016	0.013	0	41.7	39.6	67.9	132	125	0	35	33
2015	7	9	7	24	8	0.781	-0.066	4.35	0.01	0.007	0	42.6	39.6	68.4	133	125	0	34	33
2015	7	9	7	34	8	0.81	-0.072	4.35	0.01	0.007	0	42.1	39.6	67.1	132	124	0	34	32
2015	7	9	7	44	8	0.81	-0.089	4.35	0.01	0.007	0	41.7	39.6	59.3	132	125	0	35	33
2015	7	9	7	54	8	0.81	-0.095	4.35	0.01	0.007	0	42.1	38.7	58.9	132	124	0	34	34
2015	7	9	8	4	8	0.804	-0.079	4.35	0.01	0.007	0	42.6	39.6	59.3	133	125	0	34	33
2015	7	9	8	14	8	0.807	-0.108	4.35	0.01	0.007	0	42.1	39.1	59.3	132	124	0	34	33
2015	7	9	8	24	8	0.81	-0.082	4.35	0.013	0.01	0	42.1	39.1	58	132	124	0	34	33
2015	7	9	8	34	8	0.801	-0.102	4.347	0.01	0.007	0	42.1	39.6	53.3	132	124	0	34	32
2015	7	9	8	44	8	0.823	-0.085	4.35	0.01	0.007	0	41.7	38.7	55	131	123	0	34	33
2015	7	9	8	54	8	0.787	-0.105	4.35	0.01	0.007	0	41.7	39.1	52.9	132	124	0	35	33
2015	7	9	9	4	8	0.778	-0.118	4.347	0.01	0.007	0	42.1	39.1	48.6	132	124	0	34	33
2015	7	9	9	14	8	0.778	-0.115	4.347	0.013	0.01	0	41.7	39.1	53.8	131	124	0	34	33
2015	7	9	9	24	8	0.807	-0.118	4.35	0.01	0.007	0	41.3	38.7	57.2	131	123	0	35	33
2015	7	9	9	34	8	0.774	-0.148	4.347	0.01	0.007	0	41.3	38.3	53.8	130	122	0	34	33
2015	7	9	9	44	8	0.82	-0.112	4.35	0.01	0.007	0	41.3	38.7	58.5	130	123	0	34	33
2015	7	9	9	54	8	0.833	-0.148	4.35	0.01	0.007	0	41.3	38.3	64.5	130	122	0	34	33
2015	7	9	10	4	8	0.804	-0.138	4.35	0.01	0.007	0	41.7	38.7	64.5	131	123	0	34	33
2015	7	9	10	14	8	0.817	-0.125	4.35	0.01	0.007	0	41.7	38.7	65.4	131	123	0	34	33
2015	7	9	10	24	8	0.794	-0.151	4.347	0.01	0.007	0	40.9	38.3	63.6	129	122	0	34	33
2015	7	9	10	34	8	0.787	-0.105	4.35	0.01	0.007	0	40.9	37.8	67.9	129	122	0	34	34
2015	7	9	10	44	8	0.804	-0.098	4.347	0.01	0.007	0	42.1	38.7	64.5	131	123	0	33	33
2015	7	9	10	54	8	0.81	-0.069	4.347	0.013	0.01	0	42.1	39.6	63.2	132	125	0	34	33
2015	7	9	11	4	8	0.804	-0.066	4.347	0.01	0.007	0	41.7	39.1	63.2	131	124	0	34	33
2015	7	9	11	14	8	0.794	-0.089	4.347	0.013	0.01	0	41.7	39.1	55.9	131	124	0	34	33
2015	7	9	11	24	8	0.794	-0.082	4.347	0.01	0.007	0	41.7	39.1	53.8	131	124	0	34	33
2015	7	9	11	34	8	0.784	-0.102	4.347	0.01	0.007	0	42.6	39.6	54.2	133	125	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	9	11	44	8	0.774	-0.089	4.347	0.01	0.007	0	43.9	40.9	53.3	136	128	0	34	33
2015	7	9	11	54	8	0.797	-0.079	4.344	0.01	0.007	0	43	40.4	53.8	135	128	0	35	34
2015	7	9	12	4	8	0.771	-0.095	4.347	0.01	0.007	0	43.4	40.4	51.2	135	127	0	34	33
2015	7	9	12	14	8	0.761	-0.052	4.347	0.01	0.007	0	43	39.6	57.2	134	125	0	34	33
2015	7	9	12	24	8	0.778	-0.102	4.35	0.01	0.007	0	43	40	55.5	134	126	0	34	33
2015	7	9	12	34	8	0.774	-0.095	4.347	0.01	0.007	0	43	39.6	60.2	134	126	0	34	34
2015	7	9	12	44	8	0.801	-0.075	4.35	0.013	0.01	0	43	40	66.2	134	126	0	34	33
2015	7	9	12	54	8	0.807	-0.095	4.35	0.01	0.007	0	42.1	39.1	63.6	132	124	0	34	33
2015	7	9	13	4	8	0.801	-0.082	4.35	0.01	0.007	0	42.6	40	65.8	133	125	0	34	32
2015	7	9	13	14	8	0.801	-0.052	4.35	0.01	0.007	0	42.1	39.6	64.5	132	125	0	34	33
2015	7	9	13	24	8	0.781	-0.079	4.35	0.01	0.007	0	42.6	39.6	64.9	133	125	0	34	33
2015	7	9	13	34	8	0.82	-0.082	4.35	0.01	0.007	0	41.7	39.6	65.8	131	124	0	34	32
2015	7	9	13	44	8	0.791	-0.082	4.35	0.01	0.007	0	41.7	38.7	58.5	131	124	0	34	34
2015	7	9	13	54	8	0.787	-0.072	4.35	0.01	0.007	0	42.1	39.1	53.8	132	124	0	34	33
2015	7	9	14	4	8	0.778	-0.082	4.35	0.01	0.007	0	42.1	39.1	54.6	132	124	0	34	33
2015	7	9	14	14	8	0.814	-0.056	4.35	0.013	0.01	0	42.1	39.1	52	132	125	0	34	34
2015	7	9	14	24	8	0.781	-0.062	4.35	0.01	0.007	0	42.6	39.1	51.2	133	125	0	34	34
2015	7	9	14	34	8	0.797	-0.098	4.35	0.01	0.007	0	42.1	40	52.9	133	126	0	35	33
2015	7	9	14	44	8	0.791	-0.062	4.347	0.01	0.007	0	42.6	40	52	133	126	0	34	33
2015	7	9	14	54	8	0.804	-0.072	4.35	0.01	0.007	0	43	39.6	51.2	134	125	0	34	33
2015	7	9	15	4	8	0.797	-0.095	4.35	0.01	0.007	0	42.1	39.6	53.8	132	125	0	34	33
2015	7	9	15	14	8	0.794	-0.082	4.35	0.01	0.007	0	42.1	39.6	54.6	132	125	0	34	33
2015	7	9	15	24	8	0.787	-0.062	4.347	0.01	0.007	0	42.1	39.1	54.2	132	124	0	34	33
2015	7	9	15	34	8	0.82	-0.095	4.347	0.01	0.007	0	41.7	38.7	59.3	131	123	0	34	33
2015	7	9	15	44	8	0.787	-0.056	4.347	0.01	0.007	0	42.1	38.7	55	132	124	0	34	34
2015	7	9	15	54	8	0.814	-0.079	4.35	0.01	0.007	0	42.6	39.6	54.2	133	125	0	34	33
2015	7	9	16	4	8	0.774	-0.082	4.35	0.01	0.007	0	42.1	39.6	54.2	132	125	0	34	33
2015	7	9	16	14	8	0.797	-0.072	4.347	0.01	0.007	0	41.7	39.1	53.3	132	124	0	35	33
2015	7	9	16	24	8	0.804	-0.062	4.347	0.01	0.007	0	41.7	39.1	54.6	131	124	0	34	33
2015	7	9	16	34	8	0.794	-0.069	4.347	0.01	0.007	0	41.7	39.6	58	131	124	0	34	32
2015	7	9	16	44	8	0.797	-0.089	4.347	0.013	0.01	0	41.7	39.1	63.6	131	124	0	34	33
2015	7	9	16	54	8	0.787	-0.112	4.347	0.01	0.007	0	42.1	39.6	65.4	132	125	0	34	33
2015	7	9	17	4	8	0.794	-0.085	4.347	0.01	0.007	0	42.6	40	65.8	133	125	0	34	32
2015	7	9	17	14	8	0.787	-0.079	4.347	0.01	0.007	0	42.6	39.6	65.4	133	125	0	34	33
2015	7	9	17	24	8	0.778	-0.052	4.347	0.01	0.007	0	41.7	39.6	67.9	132	125	0	35	33
2015	7	9	17	34	8	0.804	-0.082	4.347	0.01	0.007	0	42.6	40	67.9	133	125	0	34	32
2015	7	9	17	44	8	0.778	-0.098	4.347	0.01	0.007	0	42.6	40	67.5	133	126	0	34	33
2015	7	9	17	54	8	0.807	-0.082	4.347	0.01	0.007	0	42.6	40	67.5	133	126	0	34	33
2015	7	9	18	4	8	0.807	-0.092	4.347	0.01	0.007	0	42.6	40	67.1	133	126	0	34	33
2015	7	9	18	14	8	0.781	-0.062	4.347	0.01	0.007	0	43.4	40.4	67.5	134	127	0	33	33
2015	7	9	18	24	8	0.823	-0.112	4.347	0.01	0.007	0	42.6	40	67.1	133	126	0	34	33
2015	7	9	18	34	8	0.807	-0.085	4.347	0.013	0.01	0	43	40	67.5	134	126	0	34	33
2015	7	9	18	44	8	0.81	-0.095	4.347	0.013	0.01	0	42.6	39.1	67.5	133	125	0	34	34
2015	7	9	18	54	8	0.801	-0.108	4.347	0.01	0.007	0	42.6	39.1	67.5	133	125	0	34	34
2015	7	9	19	4	8	0.814	-0.079	4.347	0.013	0.01	0	42.6	39.6	65.4	133	125	0	34	33
2015	7	9	19	14	8	0.807	-0.043	4.347	0.016	0.013	0	43	40	66.2	134	126	0	34	33
2015	7	9	19	24	8	0.814	-0.105	4.347	0.01	0.007	0	42.1	40.4	66.7	133	126	0	35	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	9	19	34	8	0.807	-0.082	4.347	0.01	0.007	0	43	40	66.2	134	126	0	34	33
2015	7	9	19	44	8	0.807	-0.082	4.347	0.01	0.007	0	42.6	39.6	67.1	133	125	0	34	33
2015	7	9	19	54	8	0.807	-0.095	4.347	0.01	0.007	0	42.1	39.6	67.9	132	125	0	34	33
2015	7	9	20	4	8	0.814	-0.089	4.347	0.01	0.007	0	43	40	68.4	134	126	0	34	33
2015	7	9	20	14	8	0.807	-0.089	4.347	0.013	0.01	0	42.6	40	67.5	134	126	0	35	33
2015	7	9	20	24	8	0.794	-0.052	4.347	0.01	0.007	0	42.6	40	67.5	134	126	0	35	33
2015	7	9	20	34	8	0.774	-0.082	4.347	0.013	0.01	0	43.4	40	67.1	135	127	0	34	34
2015	7	9	20	44	8	0.761	-0.056	4.35	0.013	0.01	0	43.4	40.4	65.8	136	127	0	35	33
2015	7	9	20	54	8	0.797	-0.089	4.35	0.01	0.007	0	43.9	40.9	67.1	136	128	0	34	33
2015	7	9	21	4	8	0.794	-0.118	4.347	0.016	0.013	0	43	39.6	66.7	134	125	0	34	33
2015	7	9	21	14	8	0.81	-0.085	4.35	0.01	0.007	0	43	39.6	65.4	134	125	0	34	33
2015	7	9	21	24	8	0.82	-0.072	4.35	0.01	0.007	0	42.6	39.6	66.7	134	125	0	35	33
2015	7	9	21	34	8	0.807	-0.082	4.35	0.01	0.007	0	43	40	67.9	134	126	0	34	33
2015	7	9	21	44	8	0.787	-0.098	4.35	0.013	0.01	0	43	39.6	67.5	134	125	0	34	33
2015	7	9	21	54	8	0.787	-0.095	4.35	0.01	0.007	0	42.6	39.6	67.5	133	125	0	34	33
2015	7	9	22	4	8	0.807	-0.069	4.35	0.016	0.013	0	42.6	40	66.7	133	125	0	34	32
2015	7	9	22	14	8	0.807	-0.059	4.35	0.01	0.007	0	42.6	39.6	67.9	133	125	0	34	33
2015	7	9	22	24	8	0.774	-0.069	4.35	0.013	0.01	0	43.4	39.6	69.2	134	125	0	33	33
2015	7	9	22	34	8	0.797	-0.115	4.35	0.01	0.007	0	42.1	39.1	69.7	132	124	0	34	33
2015	7	9	22	44	8	0.823	-0.049	4.35	0.01	0.007	0	42.1	39.1	69.2	133	124	0	35	33
2015	7	9	22	54	8	0.807	-0.072	4.35	0.013	0.01	0	42.6	39.1	69.7	133	124	0	34	33
2015	7	9	23	4	8	0.814	-0.095	4.35	0.013	0.01	0	42.6	39.6	69.7	133	125	0	34	33
2015	7	9	23	14	8	0.814	-0.082	4.35	0.01	0.007	0	41.7	39.1	71	132	124	0	35	33
2015	7	9	23	24	8	0.833	-0.075	4.354	0.01	0.007	0	42.6	39.6	68.4	133	125	0	34	33
2015	7	9	23	34	8	0.801	-0.069	4.35	0.01	0.007	0	43	40.4	60.6	134	126	0	34	32
2015	7	9	23	44	8	0.804	-0.066	4.354	0.01	0.007	0	42.6	39.6	67.9	133	125	0	34	33
2015	7	9	23	54	8	0.791	-0.098	4.354	0.013	0.01	0	43.4	40.4	67.5	135	126	0	34	32
2015	7	10	0	4	8	0.781	-0.079	4.354	0.01	0.007	0	43	40.4	67.1	135	127	0	35	33
2015	7	10	0	14	8	0.771	-0.072	4.354	0.01	0.007	0	43	40	70.5	135	127	0	35	34
2015	7	10	0	24	8	0.827	-0.092	4.354	0.01	0.007	0	43	40	70.1	134	126	0	34	33
2015	7	10	0	34	8	0.81	-0.079	4.354	0.01	0.007	0	43	40	70.1	134	126	0	34	33
2015	7	10	0	44	8	0.807	-0.072	4.354	0.01	0.007	0	43.4	40	68.8	135	126	0	34	33
2015	7	10	0	54	8	0.817	-0.059	4.354	0.01	0.007	0	43.9	40.4	68.8	136	128	0	34	34
2015	7	10	1	4	8	0.814	-0.062	4.354	0.01	0.007	0	43	40	69.7	135	126	0	35	33
2015	7	10	1	14	8	0.82	-0.079	4.354	0.01	0.007	0	43.4	40.4	70.5	135	127	0	34	33
2015	7	10	1	24	8	0.814	-0.089	4.354	0.013	0.01	0	43.4	39.6	70.5	135	126	0	34	34
2015	7	10	1	34	8	0.784	-0.085	4.354	0.01	0.007	0	43.4	40	69.2	135	127	0	34	34
2015	7	10	1	44	8	0.804	-0.066	4.354	0.01	0.007	0	43.4	40.4	69.7	135	127	0	34	33
2015	7	10	1	54	8	0.787	-0.069	4.354	0.013	0.01	0	43.4	40	68.4	135	126	0	34	33
2015	7	10	2	4	8	0.804	-0.098	4.354	0.01	0.007	0	43.9	40.9	70.1	136	127	0	34	32
2015	7	10	2	14	8	0.791	-0.072	4.354	0.01	0.007	0	43	40	70.5	134	126	0	34	33
2015	7	10	2	24	8	0.778	-0.066	4.354	0.01	0.007	0	42.6	39.6	69.2	134	125	0	35	33
2015	7	10	2	34	8	0.791	-0.072	4.354	0.01	0.007	0	43	39.6	70.1	134	126	0	34	34
2015	7	10	2	44	8	0.781	-0.066	4.354	0.013	0.01	0	43	39.6	69.7	135	126	0	35	34
2015	7	10	2	54	8	0.768	-0.082	4.354	0.01	0.007	0	43.4	40.4	69.2	135	127	0	34	33
2015	7	10	3	4	8	0.778	-0.026	4.354	0.01	0.007	0	43.9	40.9	69.2	136	128	0	34	33
2015	7	10	3	14	8	0.797	-0.062	4.354	0.01	0.007	0	43.4	40	69.2	135	126	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	10	3	24	8	0.794	-0.085	4.354	0.01	0.007	0	43	40.4	70.1	135	126	0	35	32
2015	7	10	3	34	8	0.794	-0.102	4.354	0.013	0.01	0	43.4	40	69.2	135	126	0	34	33
2015	7	10	3	44	8	0.807	-0.105	4.354	0.01	0.007	0	43	40	69.7	134	126	0	34	33
2015	7	10	3	54	8	0.768	-0.082	4.354	0.01	0.007	0	42.6	39.6	69.7	134	125	0	35	33
2015	7	10	4	4	8	0.778	-0.085	4.354	0.01	0.007	0	43.4	40.4	69.7	135	127	0	34	33
2015	7	10	4	14	8	0.794	-0.062	4.354	0.01	0.007	0	43	40	69.7	134	126	0	34	33
2015	7	10	4	24	8	0.82	-0.095	4.354	0.01	0.007	0	43	39.6	67.5	134	126	0	34	34
2015	7	10	4	34	8	0.781	-0.062	4.354	0.01	0.007	0	43.4	40	68.8	135	127	0	34	34
2015	7	10	4	44	8	0.784	-0.082	4.354	0.01	0.007	0	43	39.6	69.2	134	126	0	34	34
2015	7	10	4	54	8	0.764	-0.062	4.354	0.013	0.01	0	43	39.6	68.4	134	126	0	34	34
2015	7	10	5	4	8	0.784	-0.092	4.354	0.01	0.007	0	42.6	39.6	69.2	133	125	0	34	33
2015	7	10	5	14	8	0.781	-0.118	4.354	0.01	0.007	0	42.6	39.6	68.8	133	125	0	34	33
2015	7	10	5	24	8	0.781	-0.079	4.354	0.01	0.007	0	43	40	69.2	134	126	0	34	33
2015	7	10	5	34	8	0.823	-0.079	4.354	0.013	0.01	0	42.1	39.1	67.9	133	125	0	35	34
2015	7	10	5	44	8	0.778	-0.069	4.354	0.01	0.007	0	42.1	39.6	68.4	133	125	0	35	33
2015	7	10	5	54	8	0.814	-0.072	4.354	0.01	0.007	0	43	39.1	68.4	134	125	0	34	34
2015	7	10	6	4	8	0.768	-0.072	4.354	0.01	0.007	0	42.6	39.1	68.4	133	125	0	34	34
2015	7	10	6	14	8	0.83	-0.105	4.354	0.013	0.01	0	42.1	39.1	68.4	132	124	0	34	33
2015	7	10	6	24	8	0.82	-0.062	4.354	0.013	0.01	0	43	39.6	68.4	134	125	0	34	33
2015	7	10	6	34	8	0.794	-0.075	4.354	0.01	0.007	0	42.1	39.6	67.9	133	125	0	35	33
2015	7	10	6	44	8	0.781	-0.062	4.354	0.01	0.007	0	41.7	38.7	68.4	132	124	0	35	34
2015	7	10	6	54	8	0.807	-0.082	4.354	0.01	0.007	0	41.7	39.1	68.4	132	124	0	35	33
2015	7	10	7	4	8	0.83	-0.059	4.354	0.01	0.007	0	42.1	38.7	67.9	132	123	0	34	33
2015	7	10	7	14	8	0.797	-0.095	4.354	0.01	0.007	0	42.1	39.1	67.9	132	124	0	34	33
2015	7	10	7	24	8	0.784	-0.059	4.354	0.01	0.007	0	42.1	39.1	67.5	132	124	0	34	33
2015	7	10	7	34	8	0.82	-0.059	4.354	0.01	0.007	0	41.7	39.6	68.4	132	125	0	35	33
2015	7	10	7	44	8	0.787	-0.118	4.354	0.01	0.007	0	42.6	39.6	67.9	133	125	0	34	33
2015	7	10	7	54	8	0.794	-0.095	4.354	0.01	0.007	0	42.1	39.1	67.9	133	124	0	35	33
2015	7	10	8	4	8	0.781	-0.112	4.354	0.016	0.013	0	43	39.6	67.5	134	125	0	34	33
2015	7	10	8	14	8	0.768	-0.066	4.354	0.013	0.01	0	42.6	39.6	67.1	133	125	0	34	33
2015	7	10	8	24	8	0.804	-0.092	4.354	0.016	0.013	0	43	40	67.9	134	126	0	34	33
2015	7	10	8	34	8	0.807	-0.066	4.354	0.01	0.007	0	43	40	67.1	135	127	0	35	34
2015	7	10	8	44	8	0.787	-0.079	4.354	0.01	0.007	0	43	40	67.5	134	126	0	34	33
2015	7	10	8	54	8	0.84	-0.112	4.354	0.013	0.01	0	42.6	39.6	67.9	134	126	0	35	34
2015	7	10	9	4	8	0.797	-0.079	4.354	0.01	0.007	0	42.6	39.6	67.5	134	126	0	35	34
2015	7	10	9	14	8	0.827	-0.108	4.354	0.01	0.007	0	42.6	39.6	63.6	133	125	0	34	33
2015	7	10	9	24	8	0.83	-0.112	4.354	0.01	0.007	0	42.6	40	67.1	134	126	0	35	33
2015	7	10	9	34	8	0.797	-0.108	4.354	0.01	0.007	0	42.6	39.1	65.4	133	125	0	34	34
2015	7	10	9	44	8	0.81	-0.112	4.354	0.01	0.007	0	42.1	39.1	66.2	133	124	0	35	33
2015	7	10	9	54	8	0.804	-0.092	4.354	0.01	0.007	0	42.1	39.6	68.4	133	126	0	35	34
2015	7	10	10	4	8	0.797	-0.157	4.354	0.01	0.007	0	41.7	38.7	61.5	132	124	0	35	34
2015	7	10	10	14	8	0.817	-0.112	4.354	0.01	0.007	0	42.1	39.6	68.4	132	125	0	34	33
2015	7	10	10	24	8	0.804	-0.125	4.354	0.01	0.007	0	42.6	38.7	68.4	133	124	0	34	34
2015	7	10	10	34	8	0.814	-0.128	4.354	0.016	0.013	0	42.1	38.7	58	132	123	0	34	33
2015	7	10	10	44	8	0.794	-0.125	4.354	0.013	0.01	0	42.1	39.6	61.5	133	125	0	35	33
2015	7	10	10	54	8	0.833	-0.115	4.354	0.01	0.007	0	42.1	39.1	61.5	133	125	0	35	34
2015	7	10	11	4	8	0.781	-0.144	4.354	0.01	0.007	0	42.1	39.6	58.5	133	125	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	10	11	14	8	0.814	-0.128	4.354	0.01	0.007	0	41.7	39.1	66.2	132	125	0	35	34
2015	7	10	11	24	8	0.794	-0.157	4.354	0.013	0.01	0	41.7	39.1	61.1	132	124	0	35	33
2015	7	10	11	34	8	0.781	-0.167	4.354	0.01	0.007	0	41.3	38.3	55.5	131	123	0	35	34
2015	7	10	11	44	8	0.807	-0.095	4.35	0.01	0.007	0	41.7	39.1	67.5	132	124	0	35	33
2015	7	10	11	54	8	0.814	-0.128	4.35	0.013	0.01	0	41.7	38.7	66.2	132	124	0	35	34
2015	7	10	12	4	8	0.797	-0.148	4.35	0.013	0.01	0	41.7	38.3	61.9	131	123	0	34	34
2015	7	10	12	14	8	0.814	-0.161	4.35	0.01	0.007	0	41.7	38.7	56.3	132	123	0	35	33
2015	7	10	12	24	8	0.794	-0.095	4.354	0.01	0.007	0	42.6	38.7	50.3	133	124	0	34	34
2015	7	10	12	34	8	0.81	-0.151	4.35	0.01	0.007	0	42.1	39.1	67.1	132	124	0	34	33
2015	7	10	12	44	8	0.83	-0.131	4.354	0.01	0.007	0	41.7	39.1	56.3	132	124	0	35	33
2015	7	10	12	54	8	0.807	-0.105	4.354	0.013	0.01	0	42.1	39.1	55.9	132	124	0	34	33
2015	7	10	13	4	8	0.807	-0.177	4.35	0.01	0.007	0	41.7	38.7	60.6	132	123	0	35	33
2015	7	10	13	14	8	0.784	-0.121	4.35	0.01	0.007	0	42.1	39.1	55.5	133	125	0	35	34
2015	7	10	13	24	8	0.814	-0.082	4.35	0.013	0.01	0	42.1	39.6	51.6	133	125	0	35	33
2015	7	10	13	34	8	0.794	-0.144	4.347	0.013	0.01	0	41.3	38.3	65.8	131	123	0	35	34
2015	7	10	13	44	8	0.804	-0.102	4.35	0.01	0.007	0	42.6	39.1	58	133	125	0	34	34
2015	7	10	13	54	8	0.784	-0.148	4.35	0.01	0.007	0	42.1	39.1	52	132	124	0	34	33
2015	7	10	14	4	8	0.814	-0.151	4.347	0.01	0.007	0	41.7	39.1	57.2	132	124	0	35	33
2015	7	10	14	14	8	0.797	-0.141	4.347	0.013	0.01	0	42.1	38.7	56.8	132	123	0	34	33
2015	7	10	14	24	8	0.801	-0.115	4.35	0.01	0.007	0	42.6	39.6	51.6	133	125	0	34	33
2015	7	10	14	34	8	0.807	-0.105	4.347	0.01	0.007	0	42.1	39.1	49.5	132	124	0	34	33
2015	7	10	14	44	8	0.83	-0.138	4.35	0.013	0.01	0	43	39.6	49.9	134	126	0	34	34
2015	7	10	14	54	8	0.801	-0.095	4.35	0.013	0.01	0	42.6	39.6	49.5	133	125	0	34	33
2015	7	10	15	4	8	0.807	-0.148	4.347	0.01	0.007	0	42.6	39.6	49.9	133	125	0	34	33
2015	7	10	15	14	8	0.797	-0.135	4.347	0.01	0.007	0	41.7	38.7	49	132	124	0	35	34
2015	7	10	15	24	8	0.784	-0.144	4.347	0.01	0.007	0	42.6	39.1	51.2	133	125	0	34	34
2015	7	10	15	34	8	0.791	-0.148	4.347	0.01	0.007	0	42.6	39.6	49	134	126	0	35	34
2015	7	10	15	44	8	0.814	-0.105	4.347	0.01	0.007	0	42.6	39.6	67.9	133	125	0	34	33
2015	7	10	15	54	8	0.781	-0.098	4.347	0.01	0.007	0	43	39.6	53.3	134	126	0	34	34
2015	7	10	16	4	8	0.82	-0.118	4.347	0.01	0.007	0	43	39.6	63.2	134	125	0	34	33
2015	7	10	16	14	8	0.794	-0.079	4.347	0.013	0.01	0	42.6	39.6	55.5	134	126	0	35	34
2015	7	10	16	24	8	0.781	-0.105	4.35	0.01	0.007	0	43.4	40.4	54.6	136	127	0	35	33
2015	7	10	16	34	8	0.801	-0.105	4.347	0.01	0.007	0	43.4	40.4	58.9	136	128	0	35	34
2015	7	10	16	44	8	0.764	-0.046	4.347	0.01	0.007	0	43.9	40.4	64.9	136	128	0	34	34
2015	7	10	16	54	8	0.797	-0.082	4.347	0.01	0.007	0	43.4	40.4	64.1	135	127	0	34	33
2015	7	10	17	4	8	0.797	-0.092	4.347	0.01	0.007	0	43.4	40.4	66.7	135	127	0	34	33
2015	7	10	17	14	8	0.797	-0.079	4.347	0.01	0.007	0	43.4	40	64.9	135	127	0	34	34
2015	7	10	17	24	8	0.781	-0.049	4.347	0.01	0.007	0	43	40	62.8	135	126	0	35	33
2015	7	10	17	34	8	0.787	-0.069	4.347	0.01	0.007	0	43	40	59.3	134	126	0	34	33
2015	7	10	17	44	8	0.781	-0.082	4.35	0.01	0.007	0	43.9	40	57.6	136	127	0	34	34
2015	7	10	17	54	8	0.787	-0.069	4.347	0.01	0.007	0	43.9	41.3	61.9	137	129	0	35	33
2015	7	10	18	4	8	0.787	-0.092	4.347	0.01	0.007	0	43.9	40.4	67.9	136	128	0	34	34
2015	7	10	18	14	8	0.784	-0.079	4.347	0.01	0.007	0	43	40.4	69.2	135	127	0	35	33
2015	7	10	18	24	8	0.804	-0.092	4.347	0.01	0.007	0	43.4	40.4	68.8	135	127	0	34	33
2015	7	10	18	34	8	0.771	-0.049	4.347	0.013	0.01	0	43	40	67.9	135	126	0	35	33
2015	7	10	18	44	8	0.774	-0.072	4.347	0.01	0.007	0	43.4	40.4	69.2	135	127	0	34	33
2015	7	10	18	54	8	0.801	-0.098	4.347	0.01	0.007	0	43.4	40	69.7	135	126	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	10	19	4	8	0.827	-0.092	4.347	0.013	0.01	0	43	40	70.1	135	126	0	35	33
2015	7	10	19	14	8	0.81	-0.095	4.347	0.013	0.01	0	43.4	40.4	70.1	135	127	0	34	33
2015	7	10	19	24	8	0.794	-0.092	4.347	0.016	0.013	0	43.4	40.9	69.7	136	128	0	35	33
2015	7	10	19	34	8	0.794	-0.062	4.347	0.01	0.007	0	42.6	40	70.1	134	127	0	35	34
2015	7	10	19	44	8	0.837	-0.085	4.347	0.01	0.007	0	43.4	40.4	70.1	135	127	0	34	33
2015	7	10	19	54	8	0.827	-0.079	4.347	0.01	0.007	0	43.9	40.9	69.2	137	129	0	35	34
2015	7	10	20	4	8	0.81	-0.069	4.347	0.01	0.007	0	43.9	41.3	70.1	137	129	0	35	33
2015	7	10	20	14	8	0.774	-0.079	4.347	0.01	0.007	0	43.9	41.3	69.7	137	129	0	35	33
2015	7	10	20	24	8	0.794	-0.092	4.347	0.01	0.007	0	44.3	40.9	64.5	137	128	0	34	33
2015	7	10	20	34	8	0.817	-0.095	4.347	0.013	0.01	0	43.9	40.9	69.7	136	128	0	34	33
2015	7	10	20	44	8	0.787	-0.062	4.347	0.01	0.007	0	43.9	40.4	68.8	136	127	0	34	33
2015	7	10	20	54	8	0.833	-0.075	4.347	0.01	0.007	0	43.4	40.4	69.2	136	128	0	35	34
2015	7	10	21	4	8	0.797	-0.079	4.347	0.01	0.007	0	43.9	40.9	65.8	136	128	0	34	33
2015	7	10	21	14	8	0.797	-0.095	4.347	0.013	0.01	0	43	40	70.1	135	127	0	35	34
2015	7	10	21	24	8	0.794	-0.059	4.35	0.01	0.007	0	43.4	40.4	69.2	136	127	0	35	33
2015	7	10	21	34	8	0.768	-0.079	4.347	0.01	0.007	0	43	39.6	70.5	134	126	0	34	34
2015	7	10	21	44	8	0.797	-0.089	4.347	0.01	0.007	0	42.6	39.6	70.1	134	125	0	35	33
2015	7	10	21	54	8	0.794	-0.112	4.347	0.01	0.007	0	43	39.1	70.1	134	125	0	34	34
2015	7	10	22	4	8	0.797	-0.089	4.35	0.01	0.007	0	43	39.6	69.7	134	126	0	34	34
2015	7	10	22	14	8	0.778	-0.066	4.347	0.01	0.007	0	43	39.6	69.2	134	125	0	34	33
2015	7	10	22	24	8	0.797	-0.069	4.347	0.01	0.007	0	43.4	40	70.1	136	127	0	35	34
2015	7	10	22	34	8	0.833	-0.092	4.347	0.013	0.01	0	42.1	39.6	70.1	133	125	0	35	33
2015	7	10	22	44	8	0.794	-0.069	4.347	0.01	0.007	0	42.6	39.6	69.7	134	125	0	35	33
2015	7	10	22	54	8	0.797	-0.062	4.347	0.01	0.007	0	43	40	70.1	134	126	0	34	33
2015	7	10	23	4	8	0.817	-0.059	4.347	0.013	0.01	0	42.6	39.1	70.1	133	125	0	34	34
2015	7	10	23	14	8	0.787	-0.069	4.347	0.01	0.007	0	43	40	69.2	134	126	0	34	33
2015	7	10	23	24	8	0.764	-0.105	4.347	0.01	0.007	0	43	40	70.1	134	126	0	34	33
2015	7	10	23	34	8	0.81	-0.092	4.35	0.01	0.007	0	42.6	39.6	70.1	133	125	0	34	33
2015	7	10	23	44	8	0.784	-0.079	4.347	0.013	0.01	0	43	39.6	69.7	134	125	0	34	33
2015	7	10	23	54	8	0.797	-0.066	4.347	0.01	0.007	0	43	40	69.7	134	126	0	34	33
2015	7	11	0	4	8	0.804	-0.092	4.347	0.01	0.007	0	43	39.1	69.7	134	125	0	34	34
2015	7	11	0	14	8	0.781	-0.069	4.347	0.013	0.01	0	42.6	39.1	70.1	134	125	0	35	34
2015	7	11	0	24	8	0.794	-0.125	4.347	0.013	0.01	0	42.6	39.6	69.2	133	125	0	34	33
2015	7	11	0	34	8	0.797	-0.075	4.347	0.01	0.007	0	42.1	39.6	69.7	133	125	0	35	33
2015	7	11	0	44	8	0.804	-0.059	4.347	0.01	0.007	0	42.1	39.6	70.1	133	125	0	35	33
2015	7	11	0	54	8	0.81	-0.092	4.347	0.01	0.007	0	42.6	39.6	67.9	134	125	0	35	33
2015	7	11	1	4	8	0.771	-0.069	4.347	0.01	0.007	0	42.6	39.6	69.7	134	126	0	35	34
2015	7	11	1	14	8	0.794	-0.079	4.347	0.01	0.007	0	42.6	40	69.7	134	126	0	35	33
2015	7	11	1	24	8	0.83	-0.085	4.347	0.013	0.01	0	43	39.6	70.1	134	126	0	34	34
2015	7	11	1	34	8	0.804	-0.108	4.347	0.01	0.007	0	43	39.1	69.7	134	125	0	34	34
2015	7	11	1	44	8	0.768	-0.089	4.347	0.01	0.007	0	43	40	69.2	135	126	0	35	33
2015	7	11	1	54	8	0.797	-0.062	4.347	0.013	0.01	0	43	40	63.6	134	126	0	34	33
2015	7	11	2	4	8	0.787	-0.079	4.347	0.01	0.007	0	43	40	69.7	134	126	0	34	33
2015	7	11	2	14	8	0.791	-0.066	4.347	0.01	0.007	0	42.6	39.6	69.7	134	126	0	35	34
2015	7	11	2	24	8	0.787	-0.079	4.347	0.01	0.007	0	42.6	39.1	69.7	134	125	0	35	34
2015	7	11	2	34	8	0.801	-0.056	4.347	0.01	0.007	0	42.1	39.6	61.1	133	125	0	35	33
2015	7	11	2	44	8	0.814	-0.079	4.347	0.01	0.007	0	42.6	39.1	68.8	134	125	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	11	2	54	8	0.778	-0.102	4.347	0.01	0.007	0	42.1	39.1	66.2	133	125	0	35	34
2015	7	11	3	4	8	0.827	-0.085	4.347	0.013	0.01	0	42.6	40	69.7	134	126	0	35	33
2015	7	11	3	14	8	0.807	-0.089	4.347	0.013	0.01	0	42.1	38.7	69.2	133	124	0	35	34
2015	7	11	3	24	8	0.804	-0.085	4.347	0.01	0.007	0	42.6	39.6	68.8	133	125	0	34	33
2015	7	11	3	34	8	0.771	-0.092	4.347	0.01	0.007	0	42.6	39.6	69.7	133	125	0	34	33
2015	7	11	3	44	8	0.784	-0.072	4.347	0.01	0.007	0	43	39.6	67.5	134	126	0	34	34
2015	7	11	3	54	8	0.787	-0.075	4.347	0.01	0.007	0	43	39.6	68.8	135	126	0	35	34
2015	7	11	4	4	8	0.81	-0.056	4.347	0.01	0.007	0	42.6	40	68.4	134	126	0	35	33
2015	7	11	4	14	8	0.794	-0.072	4.347	0.01	0.007	0	43.4	40	69.2	135	126	0	34	33
2015	7	11	4	24	8	0.797	-0.069	4.347	0.013	0.01	0	42.6	39.6	68.4	134	125	0	35	33
2015	7	11	4	34	8	0.804	-0.079	4.347	0.01	0.007	0	43	39.6	69.2	135	126	0	35	34
2015	7	11	4	44	8	0.823	-0.121	4.344	0.01	0.007	0	42.1	39.1	69.2	133	124	0	35	33
2015	7	11	4	54	8	0.794	-0.079	4.344	0.01	0.007	0	42.6	40.4	66.7	135	127	0	36	33
2015	7	11	5	4	8	0.817	-0.066	4.347	0.013	0.01	0	43.4	39.6	68.8	135	126	0	34	34
2015	7	11	5	14	8	0.774	-0.062	4.344	0.01	0.007	0	42.6	39.1	69.2	134	125	0	35	34
2015	7	11	5	24	8	0.794	-0.095	4.344	0.01	0.007	0	42.6	39.1	68.8	134	125	0	35	34
2015	7	11	5	34	8	0.817	-0.095	4.344	0.01	0.007	0	43	39.6	68.4	134	125	0	34	33
2015	7	11	5	44	8	0.781	-0.095	4.344	0.013	0.01	0	42.1	39.6	69.2	133	125	0	35	33
2015	7	11	5	54	8	0.797	-0.095	4.344	0.01	0.007	0	42.1	39.1	68.4	133	125	0	35	34
2015	7	11	6	4	8	0.827	-0.098	4.344	0.01	0.007	0	42.1	39.6	68.8	133	125	0	35	33
2015	7	11	6	14	8	0.807	-0.098	4.344	0.01	0.007	0	42.1	39.1	68.4	133	125	0	35	34
2015	7	11	6	24	8	0.81	-0.082	4.344	0.013	0.01	0	42.6	39.1	69.2	133	125	0	34	34
2015	7	11	6	34	8	0.804	-0.085	4.344	0.013	0.01	0	42.1	39.1	68.8	133	125	0	35	34
2015	7	11	6	44	8	0.797	-0.112	4.344	0.016	0.013	0	42.6	39.1	68.4	133	125	0	34	34
2015	7	11	6	54	8	0.791	-0.056	4.344	0.013	0.01	0	43	39.6	67.1	134	126	0	34	34
2015	7	11	7	4	8	0.794	-0.095	4.344	0.01	0.007	0	42.1	39.6	68.8	133	125	0	35	33
2015	7	11	7	14	8	0.807	-0.092	4.344	0.013	0.01	0	41.7	39.1	68.4	132	124	0	35	33
2015	7	11	7	24	8	0.814	-0.092	4.344	0.01	0.007	0	42.1	39.6	69.2	133	125	0	35	33
2015	7	11	7	34	8	0.823	-0.079	4.344	0.013	0.01	0	42.6	40	68.8	134	126	0	35	33
2015	7	11	7	44	8	0.778	-0.079	4.344	0.013	0.01	0	42.6	39.1	69.2	133	125	0	34	34
2015	7	11	7	54	8	0.784	-0.098	4.344	0.01	0.007	0	42.1	39.6	69.2	133	125	0	35	33
2015	7	11	8	4	8	0.791	-0.059	4.344	0.01	0.007	0	42.1	39.1	68.8	133	125	0	35	34
2015	7	11	8	14	8	0.797	-0.095	4.344	0.01	0.007	0	42.6	39.1	69.2	133	125	0	34	34
2015	7	11	8	24	8	0.787	-0.085	4.344	0.016	0.013	0	42.6	38.7	68.8	133	124	0	34	34
2015	7	11	8	34	8	0.771	-0.069	4.344	0.01	0.007	0	42.1	39.6	69.2	133	125	0	35	33
2015	7	11	8	44	8	0.794	-0.089	4.341	0.01	0.007	0	41.7	39.1	68.8	132	124	0	35	33
2015	7	11	8	54	8	0.814	-0.085	4.341	0.013	0.01	0	42.1	39.6	69.2	133	125	0	35	33
2015	7	11	9	4	8	0.791	-0.092	4.344	0.01	0.007	0	42.6	39.1	67.9	134	125	0	35	34
2015	7	11	9	14	8	0.804	-0.092	4.341	0.013	0.01	0	42.1	39.6	68.8	133	125	0	35	33
2015	7	11	9	24	8	0.791	-0.095	4.341	0.01	0.007	0	42.6	40	68.8	134	126	0	35	33
2015	7	11	9	34	8	0.807	-0.089	4.341	0.01	0.007	0	42.6	39.6	64.1	134	126	0	35	34
2015	7	11	9	44	8	0.82	-0.112	4.341	0.01	0.007	0	41.7	39.1	64.5	132	124	0	35	33
2015	7	11	9	54	8	0.784	-0.098	4.341	0.01	0.007	0	42.1	39.1	70.1	133	125	0	35	34
2015	7	11	10	4	8	0.83	-0.135	4.341	0.01	0.007	0	41.7	39.1	69.7	132	124	0	35	33
2015	7	11	10	14	8	0.807	-0.098	4.341	0.013	0.01	0	42.1	39.1	67.9	132	124	0	34	33
2015	7	11	10	24	8	0.807	-0.072	4.341	0.01	0.007	0	42.1	39.6	67.1	133	125	0	35	33
2015	7	11	10	34	8	0.807	-0.135	4.341	0.01	0.007	0	41.7	38.7	63.6	131	124	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	11	10	44	8	0.804	-0.095	4.341	0.01	0.007	0	42.1	38.7	69.2	132	124	0	34	34
2015	7	11	10	54	8	0.758	-0.161	4.341	0.01	0.007	0	41.7	38.7	61.5	131	123	0	34	33
2015	7	11	11	4	8	0.791	-0.154	4.341	0.013	0.01	0	41.3	38.7	58.5	131	123	0	35	33
2015	7	11	11	14	8	0.804	-0.18	4.337	0.01	0.007	0	41.7	39.1	53.8	132	124	0	35	33
2015	7	11	11	24	8	0.791	-0.125	4.337	0.01	0.007	0	41.3	38.3	49.5	131	123	0	35	34
2015	7	11	11	34	8	0.761	-0.138	4.337	0.013	0.01	0	41.3	38.7	50.7	131	123	0	35	33
2015	7	11	11	44	8	0.781	-0.144	4.337	0.013	0.01	0	41.7	38.3	52	131	123	0	34	34
2015	7	11	11	54	8	0.781	-0.167	4.337	0.013	0.01	0	41.7	38.7	50.7	131	123	0	34	33
2015	7	11	12	4	8	0.801	-0.089	4.334	0.013	0.01	0	41.3	38.7	52	131	123	0	35	33
2015	7	11	12	14	8	0.807	-0.171	4.334	0.01	0.007	0	41.7	39.1	49	132	124	0	35	33
2015	7	11	12	24	8	0.797	-0.161	4.334	0.01	0.007	0	41.7	38.7	50.3	132	124	0	35	34
2015	7	11	12	34	8	0.784	-0.18	4.334	0.01	0.007	0	42.1	39.1	49.9	133	125	0	35	34
2015	7	11	12	44	8	0.787	-0.161	4.331	0.016	0.013	0	41.7	38.7	48.6	132	124	0	35	34
2015	7	11	12	54	8	0.794	-0.148	4.331	0.01	0.007	0	42.1	38.7	50.3	132	124	0	34	34
2015	7	11	13	4	8	0.791	-0.171	4.331	0.01	0.007	0	41.3	38.7	49.9	131	123	0	35	33
2015	7	11	13	14	8	0.778	-0.105	4.331	0.01	0.007	0	41.7	39.6	51.2	133	125	0	36	33
2015	7	11	13	24	8	0.794	-0.167	4.331	0.01	0.007	0	42.1	39.1	52	132	124	0	34	33
2015	7	11	13	34	8	0.791	-0.171	4.327	0.01	0.007	0	41.7	38.3	52	131	123	0	34	34
2015	7	11	13	44	8	0.83	-0.161	4.324	0.01	0.007	0	41.7	39.1	51.2	132	124	0	35	33
2015	7	11	13	54	8	0.807	-0.089	4.324	0.013	0.01	0	41.7	39.1	53.3	132	125	0	35	34
2015	7	11	14	4	8	0.794	-0.125	4.324	0.01	0.007	0	42.1	39.6	49.5	133	126	0	35	34
2015	7	11	14	14	8	0.807	-0.098	4.324	0.013	0.01	0	42.6	39.6	49	134	126	0	35	34
2015	7	11	14	24	8	0.784	-0.154	4.327	0.013	0.01	0	42.6	40	47.3	134	126	0	35	33
2015	7	11	14	34	8	0.761	-0.118	4.324	0.01	0.007	0	42.1	39.6	49.5	133	125	0	35	33
2015	7	11	14	44	8	0.761	-0.128	4.321	0.01	0.007	0	43	40	49	134	126	0	34	33
2015	7	11	14	54	8	0.761	-0.144	4.324	0.013	0.01	0	42.6	40	47.7	134	126	0	35	33
2015	7	11	15	4	8	0.774	-0.115	4.324	0.013	0.01	0	42.6	39.6	48.2	134	126	0	35	34
2015	7	11	15	14	8	0.81	-0.171	4.318	0.01	0.007	0	43.4	40.4	44.3	135	127	0	34	33
2015	7	11	15	24	8	0.814	-0.112	4.318	0.01	0.007	0	43	39.6	49.9	134	126	0	34	34
2015	7	11	15	34	8	0.801	-0.144	4.318	0.01	0.007	0	43	40	48.6	135	127	0	35	34
2015	7	11	15	44	8	0.778	-0.105	4.314	0.01	0.007	0	43.4	40.9	47.3	136	128	0	35	33
2015	7	11	15	54	8	0.768	-0.105	4.314	0.01	0.007	0	43.4	40	48.2	135	126	0	34	33
2015	7	11	16	4	8	0.778	-0.108	4.318	0.01	0.007	0	42.6	40	49.5	134	126	0	35	33
2015	7	11	16	14	8	0.778	-0.125	4.314	0.013	0.01	0	42.6	39.6	49.5	134	126	0	35	34
2015	7	11	16	24	8	0.761	-0.105	4.314	0.01	0.007	0	43	40	47.7	135	126	0	35	33
2015	7	11	16	34	8	0.778	-0.144	4.314	0.01	0.007	0	42.1	39.6	48.6	133	126	0	35	34
2015	7	11	16	44	8	0.814	-0.085	4.314	0.013	0.01	0	42.6	39.6	49.5	133	126	0	34	34
2015	7	11	16	54	8	0.761	-0.105	4.314	0.01	0.007	0	43	39.6	49.5	134	126	0	34	34
2015	7	11	17	4	8	0.791	-0.138	4.314	0.01	0.007	0	42.6	40	47.3	134	126	0	35	33
2015	7	11	17	14	8	0.774	-0.112	4.311	0.013	0.01	0	43.4	40	49.5	135	127	0	34	34
2015	7	11	17	24	8	0.764	-0.112	4.311	0.01	0.007	0	43	40	48.2	134	126	0	34	33
2015	7	11	17	34	8	0.801	-0.115	4.311	0.01	0.007	0	43	40.4	49	134	127	0	34	33
2015	7	11	17	44	8	0.784	-0.144	4.311	0.01	0.007	0	42.6	39.6	49.9	134	126	0	35	34
2015	7	11	17	54	8	0.781	-0.102	4.308	0.01	0.007	0	43	40	50.3	135	127	0	35	34
2015	7	11	18	4	8	0.778	-0.115	4.311	0.013	0.01	0	42.1	39.1	47.3	133	125	0	35	34
2015	7	11	18	14	8	0.797	-0.157	4.308	0.01	0.007	0	42.1	39.6	48.6	133	125	0	35	33
2015	7	11	18	24	8	0.774	-0.115	4.308	0.01	0.007	0	42.6	40	50.3	134	126	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	11	18	34	8	0.823	-0.125	4.308	0.013	0.01	0	42.1	39.6	55.5	133	125	0	35	33
2015	7	11	18	44	8	0.797	-0.125	4.308	0.01	0.007	0	41.7	38.7	51.6	132	124	0	35	34
2015	7	11	18	54	8	0.778	-0.135	4.308	0.013	0.01	0	41.7	39.1	51.2	132	124	0	35	33
2015	7	11	19	4	8	0.791	-0.128	4.308	0.01	0.007	0	42.6	39.6	50.7	133	125	0	34	33
2015	7	11	19	14	8	0.781	-0.079	4.308	0.01	0.007	0	43	39.6	52	134	126	0	34	34
2015	7	11	19	24	8	0.748	-0.072	4.308	0.01	0.007	0	42.6	40.4	61.5	134	127	0	35	33
2015	7	11	19	34	8	0.794	-0.092	4.304	0.01	0.007	0	42.6	39.6	59.8	133	125	0	34	33
2015	7	11	19	44	8	0.755	-0.112	4.304	0.01	0.007	0	42.1	40	61.9	133	126	0	35	33
2015	7	11	19	54	8	0.833	-0.115	4.304	0.01	0.007	0	43	39.6	55.9	134	126	0	34	34
2015	7	11	20	4	8	0.781	-0.072	4.304	0.013	0.01	0	43	39.6	63.6	134	126	0	34	34
2015	7	11	20	14	8	0.814	-0.108	4.304	0.01	0.007	0	42.6	40	60.2	134	126	0	35	33
2015	7	11	20	24	8	0.735	-0.072	4.304	0.01	0.007	0	43	40.4	57.6	135	127	0	35	33
2015	7	11	20	34	8	0.781	-0.128	4.304	0.01	0.007	0	43.4	40.4	52	135	127	0	34	33
2015	7	11	20	44	8	0.804	-0.108	4.304	0.01	0.007	0	43	40.4	57.6	135	127	0	35	33
2015	7	11	20	54	8	0.761	-0.102	4.304	0.013	0.01	0	42.6	39.6	65.8	133	126	0	34	34
2015	7	11	21	4	8	0.794	-0.098	4.304	0.01	0.007	0	43.4	40	55.5	136	127	0	35	34
2015	7	11	21	14	8	0.778	-0.105	4.304	0.01	0.007	0	43	40.4	56.8	135	127	0	35	33
2015	7	11	21	24	8	0.778	-0.085	4.304	0.01	0.007	0	43.4	40.4	57.6	136	127	0	35	33
2015	7	11	21	34	8	0.761	-0.082	4.304	0.01	0.007	0	43.4	40.4	61.1	136	127	0	35	33
2015	7	11	21	44	8	0.814	-0.102	4.304	0.01	0.007	0	43	40	69.7	134	126	0	34	33
2015	7	11	21	54	8	0.817	-0.098	4.304	0.01	0.007	0	42.6	39.6	68.4	134	125	0	35	33
2015	7	11	22	4	8	0.794	-0.075	4.304	0.01	0.007	0	43	39.6	67.5	134	126	0	34	34
2015	7	11	22	14	8	0.81	-0.112	4.304	0.01	0.007	0	42.6	39.1	69.2	134	125	0	35	34
2015	7	11	22	24	8	0.794	-0.095	4.304	0.01	0.007	0	43	39.1	66.2	134	125	0	34	34
2015	7	11	22	34	8	0.784	-0.105	4.304	0.01	0.007	0	43	39.6	69.7	134	126	0	34	34
2015	7	11	22	44	8	0.768	-0.072	4.304	0.016	0.013	0	43	40	69.2	135	126	0	35	33
2015	7	11	22	54	8	0.791	-0.105	4.304	0.01	0.007	0	42.6	40.4	69.7	134	126	0	35	32
2015	7	11	23	4	8	0.791	-0.112	4.304	0.01	0.007	0	43.4	40	70.5	135	126	0	34	33
2015	7	11	23	14	8	0.797	-0.072	4.304	0.01	0.007	0	43.4	40	68.8	135	126	0	34	33
2015	7	11	23	24	8	0.794	-0.069	4.304	0.01	0.007	0	43.4	40	70.5	135	126	0	34	33
2015	7	11	23	34	8	0.804	-0.085	4.304	0.013	0.01	0	43.4	40	70.1	135	126	0	34	33
2015	7	11	23	44	8	0.787	-0.095	4.304	0.01	0.007	0	42.6	40	70.5	134	126	0	35	33
2015	7	11	23	54	8	0.797	-0.062	4.304	0.01	0.007	0	43	39.6	66.7	134	125	0	34	33
2015	7	12	0	4	8	0.787	-0.085	4.304	0.01	0.007	0	43	40	66.7	135	126	0	35	33
2015	7	12	0	14	8	0.797	-0.095	4.304	0.013	0.01	0	43	39.1	67.1	134	125	0	34	34
2015	7	12	0	24	8	0.801	-0.089	4.304	0.01	0.007	0	42.6	39.6	70.5	134	126	0	35	34
2015	7	12	0	34	8	0.801	-0.098	4.304	0.01	0.007	0	42.6	38.7	69.2	134	124	0	35	34
2015	7	12	0	44	8	0.778	-0.075	4.304	0.01	0.007	0	42.6	39.6	70.5	134	125	0	35	33
2015	7	12	0	54	8	0.794	-0.112	4.304	0.01	0.007	0	43	39.6	58.9	135	126	0	35	34
2015	7	12	1	4	8	0.755	-0.069	4.304	0.01	0.007	0	43.4	40	70.5	135	126	0	34	33
2015	7	12	1	14	8	0.778	-0.052	4.304	0.013	0.01	0	43	40	69.7	135	126	0	35	33
2015	7	12	1	24	8	0.748	-0.072	4.304	0.013	0.01	0	43.4	40	69.7	135	126	0	34	33
2015	7	12	1	34	8	0.761	-0.062	4.304	0.01	0.007	0	43.4	40.4	68.4	136	127	0	35	33
2015	7	12	1	44	8	0.794	-0.102	4.304	0.01	0.007	0	42.6	39.6	69.7	134	126	0	35	34
2015	7	12	1	54	8	0.778	-0.089	4.304	0.01	0.007	0	43	40	70.1	135	126	0	35	33
2015	7	12	2	4	8	0.81	-0.108	4.304	0.01	0.007	0	42.6	39.6	70.5	134	125	0	35	33
2015	7	12	2	14	8	0.797	-0.102	4.301	0.01	0.007	0	42.6	39.6	70.5	134	126	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	12	2	24	8	0.781	-0.075	4.304	0.01	0.007	0	43.4	40	70.1	135	126	0	34	33
2015	7	12	2	34	8	0.83	-0.108	4.301	0.013	0.01	0	42.6	39.6	70.1	134	125	0	35	33
2015	7	12	2	44	8	0.81	-0.112	4.301	0.01	0.007	0	42.6	39.6	65.4	134	125	0	35	33
2015	7	12	2	54	8	0.827	-0.098	4.301	0.01	0.007	0	43.4	39.6	70.1	135	126	0	34	34
2015	7	12	3	4	8	0.778	-0.098	4.301	0.01	0.007	0	43	40	70.1	135	126	0	35	33
2015	7	12	3	14	8	0.768	-0.079	4.301	0.01	0.007	0	43	40	64.9	134	126	0	34	33
2015	7	12	3	24	8	0.81	-0.079	4.301	0.01	0.007	0	42.6	39.1	69.7	134	125	0	35	34
2015	7	12	3	34	8	0.784	-0.105	4.301	0.01	0.007	0	42.6	39.1	70.1	134	125	0	35	34
2015	7	12	3	44	8	0.778	-0.072	4.301	0.01	0.007	0	42.6	40	70.1	134	126	0	35	33
2015	7	12	3	54	8	0.784	-0.079	4.301	0.01	0.007	0	43	40	69.2	135	126	0	35	33
2015	7	12	4	4	8	0.797	-0.079	4.301	0.013	0.01	0	42.6	39.1	70.5	134	125	0	35	34
2015	7	12	4	14	8	0.768	-0.056	4.301	0.013	0.01	0	43	39.6	70.1	135	126	0	35	34
2015	7	12	4	24	8	0.791	-0.128	4.301	0.013	0.01	0	42.6	39.6	70.1	134	126	0	35	34
2015	7	12	4	34	8	0.781	-0.108	4.301	0.01	0.007	0	43	39.1	70.1	134	125	0	34	34
2015	7	12	4	44	8	0.82	-0.092	4.301	0.01	0.007	0	43	39.6	70.5	135	126	0	35	34
2015	7	12	4	54	8	0.768	-0.082	4.301	0.01	0.007	0	43	40	69.7	135	126	0	35	33
2015	7	12	5	4	8	0.774	-0.095	4.301	0.016	0.013	0	43	39.6	70.5	135	126	0	35	34
2015	7	12	5	14	8	0.791	-0.095	4.301	0.01	0.007	0	43	40	69.2	135	126	0	35	33
2015	7	12	5	24	8	0.791	-0.095	4.301	0.01	0.007	0	43.4	39.6	69.7	135	126	0	34	34
2015	7	12	5	34	8	0.774	-0.089	4.301	0.016	0.013	0	43	39.1	70.5	134	125	0	34	34
2015	7	12	5	44	8	0.791	-0.095	4.301	0.01	0.007	0	42.6	39.1	69.7	134	125	0	35	34
2015	7	12	5	54	8	0.787	-0.112	4.301	0.01	0.007	0	42.6	39.1	70.1	134	125	0	35	34
2015	7	12	6	4	8	0.82	-0.079	4.301	0.01	0.007	0	42.6	39.1	70.1	134	125	0	35	34
2015	7	12	6	14	8	0.787	-0.095	4.301	0.01	0.007	0	42.1	39.1	70.5	133	124	0	35	33
2015	7	12	6	24	8	0.801	-0.128	4.298	0.013	0.01	0	42.1	38.7	70.5	133	124	0	35	34
2015	7	12	6	34	8	0.787	-0.069	4.298	0.01	0.007	0	43	39.6	69.7	135	126	0	35	34
2015	7	12	6	44	8	0.801	-0.105	4.298	0.013	0.01	0	42.6	39.1	70.1	134	125	0	35	34
2015	7	12	6	54	8	0.781	-0.085	4.298	0.01	0.007	0	42.1	39.1	70.1	133	124	0	35	33
2015	7	12	7	4	8	0.771	-0.108	4.298	0.01	0.007	0	42.1	38.7	70.5	133	124	0	35	34
2015	7	12	7	14	8	0.81	-0.105	4.298	0.01	0.007	0	42.1	39.6	70.5	133	125	0	35	33
2015	7	12	7	24	8	0.787	-0.115	4.298	0.01	0.007	0	42.1	39.6	70.5	133	125	0	35	33
2015	7	12	7	34	8	0.804	-0.049	4.298	0.01	0.007	0	42.1	38.7	70.1	133	124	0	35	34
2015	7	12	7	44	8	0.797	-0.085	4.298	0.01	0.007	0	42.1	39.1	69.2	133	124	0	35	33
2015	7	12	7	54	8	0.787	-0.095	4.298	0.013	0.01	0	42.1	39.6	70.1	134	125	0	36	33
2015	7	12	8	4	8	0.771	-0.082	4.298	0.01	0.007	0	42.1	39.6	70.1	133	125	0	35	33
2015	7	12	8	14	8	0.804	-0.108	4.298	0.01	0.007	0	42.1	38.7	68.4	133	124	0	35	34
2015	7	12	8	24	8	0.791	-0.092	4.298	0.01	0.007	0	42.1	39.1	69.7	133	124	0	35	33
2015	7	12	8	34	8	0.801	-0.098	4.298	0.01	0.007	0	41.7	38.7	70.5	132	123	0	35	33
2015	7	12	8	44	8	0.771	-0.102	4.298	0.01	0.007	0	42.1	38.7	68.8	133	124	0	35	34
2015	7	12	8	54	8	0.771	-0.085	4.298	0.01	0.007	0	42.6	39.1	68.8	134	125	0	35	34
2015	7	12	9	4	8	0.764	-0.069	4.298	0.01	0.007	0	42.6	38.7	61.9	133	124	0	34	34
2015	7	12	9	14	8	0.801	-0.082	4.298	0.01	0.007	0	42.1	38.7	58.5	133	124	0	35	34
2015	7	12	9	24	8	0.817	-0.115	4.295	0.01	0.007	0	41.7	38.7	53.3	132	124	0	35	34
2015	7	12	9	34	8	0.791	-0.135	4.295	0.013	0.01	0	41.7	38.3	60.2	132	123	0	35	34
2015	7	12	9	44	8	0.774	-0.138	4.295	0.01	0.007	0	41.7	38.7	53.8	131	123	0	34	33
2015	7	12	9	54	8	0.801	-0.154	4.295	0.016	0.013	0	41.3	38.7	55.5	131	123	0	35	33
2015	7	12	10	4	8	0.791	-0.157	4.295	0.01	0.007	0	40.9	38.3	56.8	131	123	0	36	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	12	10	14	8	0.784	-0.148	4.295	0.01	0.007	0	41.7	38.7	65.4	131	123	0	34	33
2015	7	12	10	24	8	0.807	-0.148	4.291	0.01	0.007	0	41.7	38.7	57.6	132	123	0	35	33
2015	7	12	10	34	8	0.814	-0.112	4.291	0.01	0.007	0	42.1	38.7	56.3	132	123	0	34	33
2015	7	12	10	44	8	0.81	-0.112	4.291	0.016	0.013	0	41.7	38.7	53.3	132	124	0	35	34
2015	7	12	10	54	8	0.801	-0.112	4.288	0.01	0.007	0	41.7	38.3	55.9	132	123	0	35	34
2015	7	12	11	4	8	0.791	-0.128	4.288	0.01	0.007	0	42.1	39.1	55.9	132	124	0	34	33
2015	7	12	11	14	8	0.781	-0.125	4.285	0.01	0.007	0	42.1	38.7	55	132	123	0	34	33
2015	7	12	11	24	8	0.797	-0.161	4.285	0.013	0.01	0	41.3	38.7	52	131	123	0	35	33
2015	7	12	11	34	8	0.794	-0.115	4.285	0.013	0.01	0	41.7	38.7	55.5	132	124	0	35	34
2015	7	12	11	44	8	0.768	-0.177	4.285	0.013	0.01	0	41.3	38.7	48.2	131	123	0	35	33
2015	7	12	11	54	8	0.768	-0.138	4.281	0.01	0.007	0	42.1	39.1	48.6	132	124	0	34	33
2015	7	12	12	4	8	0.807	-0.138	4.281	0.01	0.007	0	41.3	38.7	55.5	131	123	0	35	33
2015	7	12	12	14	8	0.774	-0.105	4.278	0.013	0.01	0	42.1	39.6	59.3	133	125	0	35	33
2015	7	12	12	24	8	0.778	-0.141	4.278	0.01	0.007	0	42.1	39.6	54.2	133	125	0	35	33
2015	7	12	12	34	8	0.741	-0.18	4.281	0.01	0.007	0	42.1	38.7	49.9	132	123	0	34	33
2015	7	12	12	44	8	0.784	-0.138	4.278	0.01	0.007	0	42.1	39.1	52.5	133	124	0	35	33
2015	7	12	12	54	8	0.761	-0.164	4.278	0.01	0.007	0	42.1	38.7	52	132	123	0	34	33
2015	7	12	13	4	8	0.797	-0.141	4.275	0.013	0.01	0	41.7	38.3	53.8	132	123	0	35	34
2015	7	12	13	14	8	0.794	-0.161	4.275	0.01	0.007	0	42.1	38.7	49.9	133	124	0	35	34
2015	7	12	13	24	8	0.784	-0.144	4.278	0.01	0.007	0	43	39.6	51.2	134	126	0	34	34
2015	7	12	13	34	8	0.764	-0.144	4.278	0.01	0.007	0	42.6	39.6	49	134	125	0	35	33
2015	7	12	13	44	8	0.794	-0.154	4.275	0.01	0.007	0	42.1	38.7	52.5	133	124	0	35	34
2015	7	12	13	54	8	0.801	-0.187	4.275	0.01	0.007	0	42.6	39.6	49.5	133	125	0	34	33
2015	7	12	14	4	8	0.771	-0.125	4.275	0.01	0.007	0	42.6	39.6	52	133	125	0	34	33
2015	7	12	14	14	8	0.778	-0.151	4.272	0.01	0.007	0	42.6	40	47.3	134	126	0	35	33
2015	7	12	14	24	8	0.784	-0.112	4.275	0.01	0.007	0	42.6	39.1	49.9	134	125	0	35	34
2015	7	12	14	34	8	0.774	-0.194	4.275	0.013	0.01	0	42.6	39.1	50.7	133	125	0	34	34
2015	7	12	14	44	8	0.814	-0.128	4.272	0.01	0.007	0	43.9	41.3	47.3	137	129	0	35	33
2015	7	12	14	54	8	0.755	-0.135	4.272	0.013	0.01	0	43	40.4	49.9	135	127	0	35	33
2015	7	12	15	4	8	0.778	-0.18	4.268	0.01	0.007	0	43	39.6	48.2	135	126	0	35	34
2015	7	12	15	14	8	0.764	-0.135	4.268	0.01	0.007	0	43.9	40.4	49	136	127	0	34	33
2015	7	12	15	24	8	0.774	-0.161	4.272	0.013	0.01	0	43	40	49.5	135	127	0	35	34
2015	7	12	15	34	8	0.774	-0.082	4.268	0.016	0.013	0	43.4	40.4	48.2	136	128	0	35	34
2015	7	12	15	44	8	0.751	-0.128	4.272	0.01	0.007	0	43.9	40.9	48.2	136	128	0	34	33
2015	7	12	15	54	8	0.787	-0.128	4.268	0.01	0.007	0	43.4	40.9	48.6	136	128	0	35	33
2015	7	12	16	4	8	0.758	-0.138	4.265	0.01	0.007	0	43.9	40.4	49.5	136	128	0	34	34
2015	7	12	16	14	8	0.758	-0.128	4.268	0.01	0.007	0	43.9	40.4	49.5	136	128	0	34	34
2015	7	12	16	24	8	0.748	-0.128	4.265	0.01	0.007	0	43	40.4	47.7	135	127	0	35	33
2015	7	12	16	34	8	0.787	-0.112	4.265	0.01	0.007	0	43	40	49.5	135	126	0	35	33
2015	7	12	16	44	8	0.794	-0.128	4.265	0.01	0.007	0	43	40	48.2	135	127	0	35	34
2015	7	12	16	54	8	0.784	-0.144	4.262	0.013	0.01	0	43.4	40	49	135	127	0	34	34
2015	7	12	17	4	8	0.791	-0.112	4.262	0.01	0.007	0	43.4	40.4	48.2	135	127	0	34	33
2015	7	12	17	14	8	0.804	-0.102	4.262	0.01	0.007	0	43	40.4	50.7	135	127	0	35	33
2015	7	12	17	24	8	0.794	-0.085	4.262	0.01	0.007	0	43	40	50.7	135	127	0	35	34
2015	7	12	17	34	8	0.778	-0.102	4.259	0.01	0.007	0	43.9	40.4	51.2	136	128	0	34	34
2015	7	12	17	44	8	0.801	-0.079	4.262	0.01	0.007	0	44.7	41.3	46.9	138	130	0	34	34
2015	7	12	17	54	8	0.778	-0.062	4.262	0.01	0.007	0	44.3	41.3	50.3	138	130	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	12	18	4	8	0.791	-0.089	4.259	0.013	0.01	0	43.4	40.9	50.7	136	128	0	35	33
2015	7	12	18	14	8	0.797	-0.118	4.262	0.016	0.013	0	43.4	40.4	50.3	136	128	0	35	34
2015	7	12	18	24	8	0.791	-0.112	4.259	0.01	0.007	0	42.6	39.6	48.2	134	126	0	35	34
2015	7	12	18	34	8	0.787	-0.118	4.259	0.016	0.013	0	43.4	40	50.3	135	126	0	34	33
2015	7	12	18	44	8	0.807	-0.082	4.259	0.01	0.007	0	43.4	40	49.5	135	127	0	34	34
2015	7	12	18	54	8	0.748	-0.075	4.255	0.01	0.007	0	44.3	40.4	48.2	137	128	0	34	34
2015	7	12	19	4	8	0.797	-0.112	4.259	0.01	0.007	0	43.4	40.4	49.5	136	128	0	35	34
2015	7	12	19	14	8	0.764	-0.092	4.255	0.013	0.01	0	43.9	40.9	49.5	136	128	0	34	33
2015	7	12	19	24	8	0.764	-0.105	4.259	0.01	0.007	0	43.9	40.9	49.9	136	128	0	34	33
2015	7	12	19	34	8	0.814	-0.098	4.259	0.013	0.01	0	43.4	40.4	46.4	136	128	0	35	34
2015	7	12	19	44	8	0.781	-0.115	4.259	0.01	0.007	0	43.9	40	48.2	136	127	0	34	34
2015	7	12	19	54	8	0.774	-0.082	4.259	0.013	0.01	0	43.4	40.4	47.3	135	127	0	34	33
2015	7	12	20	4	8	0.764	-0.085	4.259	0.013	0.01	0	43	40.4	48.2	135	127	0	35	33
2015	7	12	20	14	8	0.784	-0.079	4.259	0.01	0.007	0	44.7	41.3	49	138	129	0	34	33
2015	7	12	20	24	8	0.797	-0.098	4.259	0.01	0.007	0	43.9	41.3	55	137	129	0	35	33
2015	7	12	20	34	8	0.787	-0.118	4.255	0.01	0.007	0	43.9	40.9	49.9	136	128	0	34	33
2015	7	12	20	44	8	0.787	-0.069	4.255	0.013	0.01	0	44.3	40.4	48.6	137	128	0	34	34
2015	7	12	20	54	8	0.797	-0.112	4.255	0.01	0.007	0	44.3	40.4	48.2	137	128	0	34	34
2015	7	12	21	4	8	0.771	-0.098	4.255	0.01	0.007	0	43.9	40.4	46.4	136	128	0	34	34
2015	7	12	21	14	8	0.794	-0.092	4.255	0.01	0.007	0	44.3	40.9	52.5	137	128	0	34	33
2015	7	12	21	24	8	0.768	-0.072	4.255	0.01	0.007	0	43.9	40.9	55.5	137	128	0	35	33
2015	7	12	21	34	8	0.807	-0.144	4.259	0.01	0.007	0	43.9	40.4	64.1	136	127	0	34	33
2015	7	12	21	44	8	0.791	-0.089	4.259	0.01	0.007	0	43.9	40	61.9	136	127	0	34	34
2015	7	12	21	54	8	0.794	-0.135	4.259	0.013	0.01	0	43	39.6	58.9	135	126	0	35	34
2015	7	12	22	4	8	0.751	-0.098	4.255	0.013	0.01	0	43.9	40.9	52.5	136	128	0	34	33
2015	7	12	22	14	8	0.755	-0.125	4.255	0.01	0.007	0	43.9	40.4	54.2	136	127	0	34	33
2015	7	12	22	24	8	0.791	-0.105	4.259	0.01	0.007	0	43.4	40.4	55.9	136	127	0	35	33
2015	7	12	22	34	8	0.758	-0.089	4.259	0.013	0.01	0	43	39.1	59.3	134	125	0	34	34
2015	7	12	22	44	8	0.778	-0.066	4.259	0.01	0.007	0	43.4	40	55.5	136	127	0	35	34
2015	7	12	22	54	8	0.755	-0.069	4.259	0.01	0.007	0	43.4	40	55.5	136	127	0	35	34
2015	7	12	23	4	8	0.801	-0.102	4.259	0.013	0.01	0	43.4	40	54.6	135	126	0	34	33
2015	7	12	23	14	8	0.794	-0.095	4.259	0.013	0.01	0	43	40	52	135	126	0	35	33
2015	7	12	23	24	8	0.81	-0.092	4.259	0.01	0.007	0	43.4	40.4	55.5	135	127	0	34	33
2015	7	12	23	34	8	0.804	-0.102	4.259	0.01	0.007	0	43	40	52.9	135	126	0	35	33
2015	7	12	23	44	8	0.794	-0.085	4.259	0.013	0.01	0	43	40	58.5	135	126	0	35	33
2015	7	12	23	54	8	0.751	-0.082	4.259	0.01	0.007	0	43.9	40.4	67.5	137	128	0	35	34
2015	7	13	0	4	8	0.801	-0.092	4.262	0.01	0.007	0	43.4	40.4	67.5	136	127	0	35	33
2015	7	13	0	14	8	0.804	-0.079	4.262	0.016	0.013	0	43.9	40.4	67.5	136	127	0	34	33
2015	7	13	0	24	8	0.781	-0.112	4.262	0.013	0.01	0	43.9	40.9	67.1	136	128	0	34	33
2015	7	13	0	34	8	0.791	-0.072	4.259	0.01	0.007	0	44.3	40.9	57.2	137	128	0	34	33
2015	7	13	0	44	8	0.741	-0.052	4.262	0.01	0.007	0	44.7	41.3	65.8	139	130	0	35	34
2015	7	13	0	54	8	0.81	-0.092	4.262	0.013	0.01	0	43.4	40	67.1	136	127	0	35	34
2015	7	13	1	4	8	0.741	-0.062	4.262	0.013	0.01	0	44.3	41.3	67.1	138	129	0	35	33
2015	7	13	1	14	8	0.787	-0.085	4.262	0.01	0.007	0	43	40.4	67.9	135	127	0	35	33
2015	7	13	1	24	8	0.761	-0.075	4.262	0.01	0.007	0	43.9	40	68.4	136	127	0	34	34
2015	7	13	1	34	8	0.787	-0.098	4.262	0.013	0.01	0	43.9	40.9	67.9	136	128	0	34	33
2015	7	13	1	44	8	0.794	-0.079	4.262	0.01	0.007	0	43	40	68.4	135	127	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	13	1	54	8	0.768	-0.069	4.262	0.01	0.007	0	43.4	40.4	62.8	135	127	0	34	33
2015	7	13	2	4	8	0.771	-0.098	4.265	0.01	0.007	0	44.3	41.3	68.8	138	129	0	35	33
2015	7	13	2	14	8	0.778	-0.108	4.265	0.016	0.013	0	43.9	40.4	69.2	136	127	0	34	33
2015	7	13	2	24	8	0.781	-0.092	4.265	0.013	0.01	0	43.4	40	69.2	136	127	0	35	34
2015	7	13	2	34	8	0.761	-0.085	4.265	0.01	0.007	0	44.3	40.9	69.2	137	128	0	34	33
2015	7	13	2	44	8	0.781	-0.039	4.265	0.01	0.007	0	43.9	40.9	70.1	136	128	0	34	33
2015	7	13	2	54	8	0.787	-0.092	4.265	0.01	0.007	0	43	40	69.7	135	126	0	35	33
2015	7	13	3	4	8	0.774	-0.056	4.265	0.01	0.007	0	43.9	40.9	69.2	136	128	0	34	33
2015	7	13	3	14	8	0.758	-0.072	4.265	0.01	0.007	0	43.9	40	69.2	136	127	0	34	34
2015	7	13	3	24	8	0.768	-0.079	4.265	0.01	0.007	0	43.9	40.4	69.7	137	128	0	35	34
2015	7	13	3	34	8	0.771	-0.069	4.265	0.01	0.007	0	43	40	69.7	135	127	0	35	34
2015	7	13	3	44	8	0.791	-0.066	4.265	0.01	0.007	0	43.9	40	69.7	136	127	0	34	34
2015	7	13	3	54	8	0.781	-0.092	4.265	0.013	0.01	0	43.4	40.9	69.7	136	128	0	35	33
2015	7	13	4	4	8	0.778	-0.089	4.265	0.01	0.007	0	43.4	40	70.1	136	127	0	35	34
2015	7	13	4	14	8	0.778	-0.095	4.265	0.01	0.007	0	43	40.4	69.7	135	126	0	35	32
2015	7	13	4	24	8	0.781	-0.095	4.265	0.01	0.007	0	43.9	40.9	69.7	136	128	0	34	33
2015	7	13	4	34	8	0.748	-0.075	4.265	0.013	0.01	0	43.9	40.4	70.1	136	127	0	34	33
2015	7	13	4	44	8	0.81	-0.108	4.265	0.016	0.013	0	43	40	70.1	135	126	0	35	33
2015	7	13	4	54	8	0.784	-0.082	4.265	0.01	0.007	0	43.4	40.4	69.7	136	127	0	35	33
2015	7	13	5	4	8	0.781	-0.095	4.265	0.01	0.007	0	44.3	41.3	70.1	137	129	0	34	33
2015	7	13	5	14	8	0.797	-0.102	4.265	0.013	0.01	0	43	39.6	70.5	135	126	0	35	34
2015	7	13	5	24	8	0.741	-0.062	4.265	0.01	0.007	0	43.4	40.4	70.1	136	127	0	35	33
2015	7	13	5	34	8	0.787	-0.102	4.265	0.01	0.007	0	43.4	40	70.1	135	127	0	34	34
2015	7	13	5	44	8	0.794	-0.089	4.265	0.01	0.007	0	43.4	40.4	69.7	136	127	0	35	33
2015	7	13	5	54	8	0.794	-0.079	4.265	0.01	0.007	0	43	40	70.1	135	127	0	35	34
2015	7	13	6	4	8	0.755	-0.082	4.265	0.01	0.007	0	43.9	40	70.5	136	126	0	34	33
2015	7	13	6	14	8	0.758	-0.112	4.265	0.01	0.007	0	43	40	71	135	126	0	35	33
2015	7	13	6	24	8	0.735	-0.121	4.265	0.013	0.01	0	43	39.6	70.5	135	126	0	35	34
2015	7	13	6	34	8	0.801	-0.089	4.265	0.01	0.007	0	43.4	40	71.4	135	126	0	34	33
2015	7	13	6	44	8	0.778	-0.085	4.265	0.013	0.01	0	43.9	40.4	70.5	136	127	0	34	33
2015	7	13	6	54	8	0.755	-0.095	4.265	0.01	0.007	0	43.9	40.9	70.5	137	128	0	35	33
2015	7	13	7	4	8	0.781	-0.092	4.265	0.01	0.007	0	43.9	40.9	68.8	137	128	0	35	33
2015	7	13	7	14	8	0.778	-0.095	4.265	0.01	0.007	0	43	40	66.7	135	126	0	35	33
2015	7	13	7	24	8	0.781	-0.112	4.265	0.01	0.007	0	43.9	40.9	71	136	128	0	34	33
2015	7	13	7	34	8	0.787	-0.102	4.265	0.01	0.007	0	43.4	39.6	71	135	126	0	34	34
2015	7	13	7	44	8	0.778	-0.089	4.265	0.01	0.007	0	43.4	40.4	71	135	127	0	34	33
2015	7	13	7	54	8	0.784	-0.121	4.265	0.01	0.007	0	42.6	40	71.4	134	126	0	35	33
2015	7	13	8	4	8	0.794	-0.095	4.265	0.01	0.007	0	43.4	39.6	71	135	126	0	34	34
2015	7	13	8	14	8	0.784	-0.089	4.265	0.01	0.007	0	42.6	39.6	70.1	134	125	0	35	33
2015	7	13	8	24	8	0.764	-0.066	4.265	0.01	0.007	0	43	40	70.5	134	126	0	34	33
2015	7	13	8	34	8	0.784	-0.098	4.265	0.01	0.007	0	43	40.4	70.5	135	127	0	35	33
2015	7	13	8	44	8	0.794	-0.095	4.265	0.01	0.007	0	42.6	39.6	70.5	134	126	0	35	34
2015	7	13	8	54	8	0.745	-0.075	4.265	0.01	0.007	0	43	40	70.5	135	126	0	35	33
2015	7	13	9	4	8	0.794	-0.118	4.265	0.013	0.01	0	43	40	70.1	134	126	0	34	33
2015	7	13	9	14	8	0.784	-0.098	4.265	0.01	0.007	0	42.6	40	70.1	134	126	0	35	33
2015	7	13	9	24	8	0.768	-0.082	4.265	0.01	0.007	0	43.4	40	69.2	135	126	0	34	33
2015	7	13	9	34	8	0.764	-0.075	4.265	0.01	0.007	0	43.4	40	69.2	135	127	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	13	9	44	8	0.791	-0.115	4.265	0.01	0.007	0	43	39.6	69.2	134	126	0	34	34
2015	7	13	9	54	8	0.771	-0.085	4.265	0.01	0.007	0	42.6	39.6	68.4	134	126	0	35	34
2015	7	13	10	4	8	0.758	-0.105	4.262	0.016	0.013	0	42.6	40	65.8	134	126	0	35	33
2015	7	13	10	14	8	0.807	-0.112	4.262	0.01	0.007	0	43	39.6	64.1	134	126	0	34	34
2015	7	13	10	24	8	0.791	-0.098	4.262	0.01	0.007	0	43.4	39.6	63.2	135	126	0	34	34
2015	7	13	10	34	8	0.817	-0.108	4.262	0.01	0.007	0	42.6	39.6	62.8	134	126	0	35	34
2015	7	13	10	44	8	0.784	-0.098	4.262	0.01	0.007	0	42.6	40	58.9	134	127	0	35	34
2015	7	13	10	54	8	0.804	-0.112	4.262	0.01	0.007	0	43	40	66.7	134	126	0	34	33
2015	7	13	11	4	8	0.758	-0.18	4.262	0.01	0.007	0	42.6	39.6	62.8	133	124	0	34	32
2015	7	13	11	14	8	0.771	-0.085	4.262	0.013	0.01	0	43	39.1	67.5	134	125	0	34	34
2015	7	13	11	24	8	0.781	-0.115	4.259	0.01	0.007	0	43	40	60.2	134	126	0	34	33
2015	7	13	11	34	8	0.791	-0.171	4.259	0.013	0.01	0	42.1	39.1	62.4	133	124	0	35	33
2015	7	13	11	44	8	0.771	-0.161	4.259	0.01	0.007	0	42.6	39.6	61.5	133	125	0	34	33
2015	7	13	11	54	8	0.774	-0.177	4.255	0.013	0.01	0	42.1	39.1	56.3	133	125	0	35	34
2015	7	13	12	4	8	0.768	-0.177	4.255	0.01	0.007	0	42.1	39.1	62.4	133	125	0	35	34
2015	7	13	12	14	8	0.774	-0.121	4.252	0.01	0.007	0	42.1	39.6	56.8	133	125	0	35	33
2015	7	13	12	24	8	0.787	-0.092	4.252	0.013	0.01	0	43	40	53.8	134	126	0	34	33
2015	7	13	12	34	8	0.768	-0.154	4.252	0.013	0.01	0	42.6	39.1	55.5	133	125	0	34	34
2015	7	13	12	44	8	0.771	-0.174	4.249	0.01	0.007	0	42.6	39.1	53.3	133	124	0	34	33
2015	7	13	12	54	8	0.768	-0.135	4.249	0.01	0.007	0	42.6	39.6	55.5	133	125	0	34	33
2015	7	13	13	4	8	0.761	-0.131	4.249	0.01	0.007	0	42.1	39.6	52.5	133	125	0	35	33
2015	7	13	13	14	8	0.797	-0.128	4.245	0.01	0.007	0	42.1	39.6	65.4	133	125	0	35	33
2015	7	13	13	24	8	0.778	-0.131	4.245	0.01	0.007	0	42.6	39.1	57.6	133	124	0	34	33
2015	7	13	13	34	8	0.771	-0.174	4.245	0.01	0.007	0	43	39.6	50.7	134	126	0	34	34
2015	7	13	13	44	8	0.755	-0.102	4.249	0.01	0.007	0	43	39.6	52	134	126	0	34	34
2015	7	13	13	54	8	0.755	-0.151	4.245	0.01	0.007	0	42.6	39.6	51.2	134	125	0	35	33
2015	7	13	14	4	8	0.778	-0.112	4.242	0.016	0.013	0	43	39.6	58	134	126	0	34	34
2015	7	13	14	14	8	0.801	-0.138	4.242	0.01	0.007	0	42.6	40	55	134	126	0	35	33
2015	7	13	14	24	8	0.768	-0.157	4.242	0.01	0.007	0	43	39.6	53.3	134	125	0	34	33
2015	7	13	14	34	8	0.784	-0.112	4.245	0.013	0.01	0	43.4	40.4	50.7	135	127	0	34	33
2015	7	13	14	44	8	0.774	-0.095	4.242	0.01	0.007	0	42.1	39.6	52.5	133	125	0	35	33
2015	7	13	14	54	8	0.781	-0.157	4.242	0.01	0.007	0	42.6	40	51.2	134	126	0	35	33
2015	7	13	15	4	8	0.755	-0.135	4.242	0.013	0.01	0	43	40.4	48.6	135	127	0	35	33
2015	7	13	15	14	8	0.755	-0.135	4.239	0.01	0.007	0	42.6	40	52	134	126	0	35	33
2015	7	13	15	24	8	0.751	-0.174	4.242	0.01	0.007	0	43	40	51.2	135	126	0	35	33
2015	7	13	15	34	8	0.755	-0.151	4.239	0.01	0.007	0	43	40	50.7	134	126	0	34	33
2015	7	13	15	44	8	0.741	-0.115	4.242	0.013	0.01	0	43.4	40.9	48.6	136	128	0	35	33
2015	7	13	15	54	8	0.807	-0.082	4.242	0.01	0.007	0	43.9	40.4	49.9	136	127	0	34	33
2015	7	13	16	4	8	0.764	-0.131	4.239	0.01	0.007	0	43.4	40.4	46.9	135	127	0	34	33
2015	7	13	16	14	8	0.791	-0.098	4.239	0.01	0.007	0	43	40.4	48.6	135	127	0	35	33
2015	7	13	16	24	8	0.787	-0.125	4.239	0.01	0.007	0	43.4	40.9	49	135	127	0	34	32
2015	7	13	16	34	8	0.787	-0.131	4.242	0.013	0.01	0	44.3	40.4	48.2	136	127	0	33	33
2015	7	13	16	44	8	0.764	-0.115	4.242	0.01	0.007	0	43.9	40.4	46	136	127	0	34	33
2015	7	13	16	54	8	0.764	-0.105	4.239	0.01	0.007	0	43.4	40.4	48.6	136	127	0	35	33
2015	7	13	17	4	8	0.751	-0.079	4.239	0.01	0.007	0	43.9	40.9	49.9	136	128	0	34	33
2015	7	13	17	14	8	0.784	-0.135	4.239	0.01	0.007	0	43.9	40.9	48.6	136	128	0	34	33
2015	7	13	17	24	8	0.755	-0.118	4.236	0.013	0.01	0	43	40.4	49.5	134	128	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	13	17	34	8	0.784	-0.128	4.236	0.013	0.01	0	43.4	40.4	51.6	136	127	0	35	33
2015	7	13	17	44	8	0.764	-0.105	4.236	0.01	0.007	0	44.3	40.9	47.7	137	128	0	34	33
2015	7	13	17	54	8	0.801	-0.085	4.236	0.01	0.007	0	44.3	41.3	49.5	137	129	0	34	33
2015	7	13	18	4	8	0.778	-0.118	4.236	0.01	0.007	0	43.4	40.4	49.9	136	128	0	35	34
2015	7	13	18	14	8	0.784	-0.144	4.236	0.01	0.007	0	43.4	40.4	48.6	135	127	0	34	33
2015	7	13	18	24	8	0.755	-0.118	4.236	0.01	0.007	0	43.9	40.9	49	136	128	0	34	33
2015	7	13	18	34	8	0.787	-0.131	4.236	0.013	0.01	0	43.4	40	45.2	135	126	0	34	33
2015	7	13	18	44	8	0.804	-0.125	4.236	0.016	0.013	0	43.4	40	50.3	135	126	0	34	33
2015	7	13	18	54	8	0.797	-0.105	4.229	0.013	0.01	0	44.7	40.4	42.6	138	127	0	34	33
2015	7	13	19	4	8	0.778	-0.085	4.232	0.01	0.007	0	47.7	43.9	37.8	145	135	0	34	33
2015	7	13	19	14	8	0.794	-0.112	4.236	0.01	0.007	0	43	40.4	50.3	135	127	0	35	33
2015	7	13	19	24	8	0.784	-0.115	4.236	0.01	0.007	0	44.3	40	46	137	127	0	34	34
2015	7	13	19	34	8	0.801	-0.144	4.236	0.01	0.007	0	43.4	40.4	58.5	135	127	0	34	33
2015	7	13	19	44	8	0.801	-0.108	4.236	0.013	0.01	0	42.6	40	61.1	134	126	0	35	33
2015	7	13	19	54	8	0.761	-0.082	4.236	0.01	0.007	0	43.9	40.9	63.6	136	128	0	34	33
2015	7	13	20	4	8	0.764	-0.079	4.236	0.01	0.007	0	43.9	40.4	55.9	137	128	0	35	34
2015	7	13	20	14	8	0.787	-0.075	4.236	0.01	0.007	0	44.3	40.4	57.2	137	128	0	34	34
2015	7	13	20	24	8	0.764	-0.115	4.236	0.013	0.01	0	44.3	41.7	61.9	137	129	0	34	32
2015	7	13	20	34	8	0.784	-0.105	4.236	0.01	0.007	0	43.9	40.9	55.5	137	128	0	35	33
2015	7	13	20	44	8	0.781	-0.089	4.236	0.01	0.007	0	44.3	41.3	50.7	137	129	0	34	33
2015	7	13	20	54	8	0.761	-0.108	4.236	0.01	0.007	0	45.2	41.7	61.5	139	130	0	34	33
2015	7	13	21	4	8	0.801	-0.112	4.236	0.013	0.01	0	43.4	40.9	55.9	136	128	0	35	33
2015	7	13	21	14	8	0.761	-0.102	4.239	0.01	0.007	0	44.3	41.3	52.5	137	128	0	34	32
2015	7	13	21	24	8	0.794	-0.092	4.239	0.01	0.007	0	44.3	40.4	54.2	137	128	0	34	34
2015	7	13	21	34	8	0.768	-0.102	4.239	0.016	0.013	0	43.9	40.4	56.3	136	127	0	34	33
2015	7	13	21	44	8	0.801	-0.112	4.239	0.01	0.007	0	43.9	40	60.6	136	127	0	34	34
2015	7	13	21	54	8	0.791	-0.098	4.239	0.013	0.01	0	43	40.9	61.5	135	127	0	35	32
2015	7	13	22	4	8	0.794	-0.102	4.239	0.013	0.01	0	43.9	40.4	69.7	136	127	0	34	33
2015	7	13	22	14	8	0.764	-0.072	4.239	0.01	0.007	0	43.9	40.4	70.5	136	127	0	34	33
2015	7	13	22	24	8	0.755	-0.105	4.239	0.013	0.01	0	43.4	40.4	69.2	136	127	0	35	33
2015	7	13	22	34	8	0.771	-0.079	4.239	0.01	0.007	0	43.4	40.4	67.5	136	127	0	35	33
2015	7	13	22	44	8	0.797	-0.138	4.239	0.01	0.007	0	43.4	40.9	69.7	136	128	0	35	33
2015	7	13	22	54	8	0.771	-0.092	4.239	0.01	0.007	0	44.3	40.4	69.7	137	128	0	34	34
2015	7	13	23	4	8	0.778	-0.075	4.239	0.01	0.007	0	43.9	40.4	69.2	136	127	0	34	33
2015	7	13	23	14	8	0.764	-0.072	4.239	0.013	0.01	0	43.4	40.4	69.7	136	127	0	35	33
2015	7	13	23	24	8	0.771	-0.098	4.239	0.016	0.013	0	43.4	40.9	70.5	135	127	0	34	32
2015	7	13	23	34	8	0.768	-0.085	4.239	0.013	0.01	0	44.3	40.4	69.7	137	128	0	34	34
2015	7	13	23	44	8	0.758	-0.095	4.239	0.013	0.01	0	43.9	40.4	69.7	136	128	0	34	34
2015	7	13	23	54	8	0.758	-0.098	4.239	0.01	0.007	0	43.9	40.9	68.8	136	128	0	34	33
2015	7	14	0	4	8	0.771	-0.118	4.239	0.013	0.01	0	43.4	40.9	69.7	136	128	0	35	33
2015	7	14	0	14	8	0.758	-0.089	4.239	0.01	0.007	0	43.4	40.9	68.8	135	127	0	34	32
2015	7	14	0	24	8	0.804	-0.095	4.239	0.01	0.007	0	43.9	40.4	67.1	136	128	0	34	34
2015	7	14	0	34	8	0.751	-0.082	4.242	0.013	0.01	0	44.3	40.9	69.7	137	128	0	34	33
2015	7	14	0	44	8	0.781	-0.112	4.242	0.01	0.007	0	43.9	40.4	69.2	136	127	0	34	33
2015	7	14	0	54	8	0.758	-0.095	4.239	0.01	0.007	0	43.9	40.9	69.2	136	128	0	34	33
2015	7	14	1	4	8	0.778	-0.079	4.239	0.016	0.013	0	44.3	40.4	69.2	137	128	0	34	34
2015	7	14	1	14	8	0.768	-0.102	4.242	0.01	0.007	0	43.9	40	69.2	136	127	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	14	1	24	8	0.787	-0.112	4.242	0.01	0.007	0	43.4	40	68.4	135	127	0	34	34
2015	7	14	1	34	8	0.751	-0.098	4.242	0.01	0.007	0	43.9	40.9	69.2	136	128	0	34	33
2015	7	14	1	44	8	0.787	-0.089	4.242	0.013	0.01	0	43	40.4	68.8	135	127	0	35	33
2015	7	14	1	54	8	0.778	-0.075	4.242	0.01	0.007	0	43	40.4	69.2	135	127	0	35	33
2015	7	14	2	4	8	0.804	-0.095	4.242	0.01	0.007	0	43.9	40.4	69.7	136	128	0	34	34
2015	7	14	2	14	8	0.738	-0.075	4.242	0.01	0.007	0	43.9	40.4	69.2	136	127	0	34	33
2015	7	14	2	24	8	0.771	-0.092	4.242	0.01	0.007	0	43	40	69.2	134	126	0	34	33
2015	7	14	2	34	8	0.771	-0.131	4.242	0.013	0.01	0	43.4	40.4	69.2	135	127	0	34	33
2015	7	14	2	44	8	0.791	-0.095	4.242	0.01	0.007	0	43.4	40	69.2	135	126	0	34	33
2015	7	14	2	54	8	0.751	-0.092	4.242	0.01	0.007	0	43.9	40.9	67.9	136	128	0	34	33
2015	7	14	3	4	8	0.781	-0.098	4.242	0.01	0.007	0	43.4	40.4	68.4	136	127	0	35	33
2015	7	14	3	14	8	0.784	-0.092	4.245	0.01	0.007	0	43.4	40.4	67.5	136	127	0	35	33
2015	7	14	3	24	8	0.761	-0.075	4.245	0.013	0.01	0	43.4	40.9	67.1	136	128	0	35	33
2015	7	14	3	34	8	0.787	-0.062	4.245	0.01	0.007	0	43.9	40.9	66.7	136	128	0	34	33
2015	7	14	3	44	8	0.735	-0.075	4.245	0.01	0.007	0	44.3	40.4	66.2	137	128	0	34	34
2015	7	14	3	54	8	0.794	-0.085	4.245	0.01	0.007	0	44.3	40	66.7	137	127	0	34	34
2015	7	14	4	4	8	0.768	-0.082	4.245	0.01	0.007	0	43.9	40.9	66.2	137	128	0	35	33
2015	7	14	4	14	8	0.794	-0.075	4.245	0.01	0.007	0	43.9	40.4	66.7	137	128	0	35	34
2015	7	14	4	24	8	0.725	-0.089	4.245	0.01	0.007	0	44.3	40.9	66.7	137	128	0	34	33
2015	7	14	4	34	8	0.771	-0.112	4.245	0.013	0.01	0	43.9	40.4	66.7	136	127	0	34	33
2015	7	14	4	44	8	0.81	-0.085	4.249	0.013	0.01	0	44.3	40.9	66.7	137	128	0	34	33
2015	7	14	4	54	8	0.778	-0.069	4.245	0.01	0.007	0	44.3	40.9	66.2	137	128	0	34	33
2015	7	14	5	4	8	0.761	-0.082	4.249	0.01	0.007	0	44.7	41.7	62.8	139	130	0	35	33
2015	7	14	5	14	8	0.781	-0.098	4.249	0.01	0.007	0	43.9	40.9	66.2	137	128	0	35	33
2015	7	14	5	24	8	0.768	-0.082	4.249	0.01	0.007	0	45.2	41.7	65.8	140	131	0	35	34
2015	7	14	5	34	8	0.784	-0.079	4.249	0.01	0.007	0	44.7	41.3	64.9	138	130	0	34	34
2015	7	14	5	44	8	0.801	-0.089	4.249	0.01	0.007	0	44.7	41.3	65.4	138	129	0	34	33
2015	7	14	5	54	8	0.787	-0.098	4.252	0.01	0.007	0	43.9	40.4	66.7	137	128	0	35	34
2015	7	14	6	4	8	0.755	-0.082	4.255	0.01	0.007	0	44.7	41.7	65.8	138	130	0	34	33
2015	7	14	6	14	8	0.771	-0.066	4.255	0.01	0.007	0	44.3	40.9	66.7	137	128	0	34	33
2015	7	14	6	24	8	0.787	-0.075	4.255	0.013	0.01	0	43.9	40	66.7	136	127	0	34	34
2015	7	14	6	34	8	0.751	-0.079	4.259	0.013	0.01	0	43.4	40.4	66.7	135	127	0	34	33
2015	7	14	6	44	8	0.784	-0.069	4.259	0.01	0.007	0	43.4	40	66.7	135	126	0	34	33
2015	7	14	6	54	8	0.758	-0.095	4.259	0.01	0.007	0	43.4	40	67.1	135	126	0	34	33
2015	7	14	7	4	8	0.728	-0.092	4.259	0.01	0.007	0	43.4	40	67.5	135	126	0	34	33
2015	7	14	7	14	8	0.784	-0.082	4.259	0.013	0.01	0	43	40.4	65.8	135	127	0	35	33
2015	7	14	7	24	8	0.797	-0.095	4.259	0.01	0.007	0	43.4	40.4	66.7	136	127	0	35	33
2015	7	14	7	34	8	0.761	-0.092	4.259	0.01	0.007	0	43.4	40.4	67.1	136	127	0	35	33
2015	7	14	7	44	8	0.781	-0.098	4.259	0.01	0.007	0	43.4	40	67.5	135	126	0	34	33
2015	7	14	7	54	8	0.764	-0.079	4.259	0.01	0.007	0	43.4	40.4	67.1	136	127	0	35	33
2015	7	14	8	4	8	0.774	-0.112	4.259	0.01	0.007	0	43.4	40	67.9	135	127	0	34	34
2015	7	14	8	14	8	0.771	-0.092	4.259	0.01	0.007	0	43.4	40	67.1	135	126	0	34	33
2015	7	14	8	24	8	0.768	-0.115	4.259	0.013	0.01	0	43.4	40.9	67.1	135	127	0	34	32
2015	7	14	8	34	8	0.764	-0.112	4.259	0.013	0.01	0	43	40	67.5	135	127	0	35	34
2015	7	14	8	44	8	0.778	-0.085	4.259	0.01	0.007	0	43	39.6	67.1	134	126	0	34	34
2015	7	14	8	54	8	0.768	-0.092	4.259	0.01	0.007	0	43.4	40.4	66.2	135	127	0	34	33
2015	7	14	9	4	8	0.768	-0.098	4.259	0.01	0.007	0	43.4	40.4	67.1	135	127	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	14	9	14	8	0.768	-0.125	4.255	0.013	0.01	0	43.4	40	60.6	135	127	0	34	34
2015	7	14	9	24	8	0.774	-0.131	4.255	0.01	0.007	0	43.4	40	65.8	135	126	0	34	33
2015	7	14	9	34	8	0.804	-0.125	4.252	0.013	0.01	0	43.4	40	66.2	135	126	0	34	33
2015	7	14	9	44	8	0.784	-0.131	4.249	0.01	0.007	0	42.1	39.6	54.2	133	125	0	35	33
2015	7	14	9	54	8	0.794	-0.112	4.249	0.01	0.007	0	43	40	61.9	134	126	0	34	33
2015	7	14	10	4	8	0.784	-0.148	4.249	0.01	0.007	0	42.6	40	62.8	134	126	0	35	33
2015	7	14	10	14	8	0.748	-0.161	4.245	0.01	0.007	0	42.1	39.6	61.9	133	125	0	35	33
2015	7	14	10	24	8	0.774	-0.171	4.245	0.013	0.01	0	42.6	39.6	60.2	133	125	0	34	33
2015	7	14	10	34	8	0.778	-0.135	4.245	0.01	0.007	0	42.6	40	63.2	134	126	0	35	33
2015	7	14	10	44	8	0.778	-0.125	4.245	0.01	0.007	0	42.6	40	64.1	134	126	0	35	33
2015	7	14	10	54	8	0.768	-0.112	4.245	0.01	0.007	0	43	40	63.2	134	126	0	34	33
2015	7	14	11	4	8	0.722	-0.167	4.245	0.013	0.01	0	42.6	40	52.5	134	126	0	35	33
2015	7	14	11	14	8	0.771	-0.144	4.245	0.01	0.007	0	43	40.4	66.7	134	126	0	34	32
2015	7	14	11	24	8	0.784	-0.115	4.245	0.01	0.007	0	42.6	39.6	55.5	133	125	0	34	33
2015	7	14	11	34	8	0.751	-0.171	4.245	0.01	0.007	0	42.6	39.1	58	134	125	0	35	34
2015	7	14	11	44	8	0.787	-0.19	4.245	0.013	0.01	0	42.6	40	55.9	134	126	0	35	33
2015	7	14	11	54	8	0.771	-0.161	4.245	0.01	0.007	0	42.6	39.6	54.2	133	125	0	34	33
2015	7	14	12	4	8	0.804	-0.112	4.245	0.01	0.007	0	43	39.6	52.5	134	126	0	34	34
2015	7	14	12	14	8	0.778	-0.131	4.245	0.01	0.007	0	42.6	40	54.2	133	126	0	34	33
2015	7	14	12	24	8	0.768	-0.157	4.242	0.01	0.007	0	42.1	38.7	52.9	133	124	0	35	34
2015	7	14	12	34	8	0.764	-0.164	4.245	0.013	0.01	0	42.6	39.6	49	133	125	0	34	33
2015	7	14	12	44	8	0.758	-0.177	4.242	0.01	0.007	0	42.6	39.6	50.7	133	125	0	34	33
2015	7	14	12	54	8	0.738	-0.18	4.242	0.013	0.01	0	42.6	40	53.3	134	126	0	35	33
2015	7	14	13	4	8	0.781	-0.161	4.245	0.01	0.007	0	43	40	49	134	126	0	34	33
2015	7	14	13	14	8	0.771	-0.098	4.242	0.016	0.013	0	43	39.6	52.5	134	126	0	34	34
2015	7	14	13	24	8	0.768	-0.174	4.239	0.01	0.007	0	43.4	39.6	47.3	135	126	0	34	34
2015	7	14	13	34	8	0.761	-0.125	4.242	0.01	0.007	0	46.4	43	44.7	142	133	0	34	33
2015	7	14	13	44	8	0.751	-0.115	4.239	0.01	0.007	0	44.3	42.1	50.7	138	131	0	35	33
2015	7	14	13	54	8	0.774	-0.105	4.242	0.013	0.01	0	43.9	41.3	47.3	136	130	0	34	34
2015	7	14	14	4	8	0.794	-0.095	4.239	0.01	0.007	0	44.3	41.3	46.9	137	129	0	34	33
2015	7	14	14	14	8	0.755	-0.148	4.239	0.01	0.007	0	43.4	40	52	135	126	0	34	33
2015	7	14	14	24	8	0.774	-0.082	4.239	0.01	0.007	0	42.6	40.4	47.3	134	127	0	35	33
2015	7	14	14	34	8	0.787	-0.098	4.239	0.01	0.007	0	43.4	40.4	48.6	135	127	0	34	33
2015	7	14	14	44	8	0.784	-0.079	4.239	0.013	0.01	0	43.4	40.9	49	136	128	0	35	33
2015	7	14	14	54	8	0.791	-0.164	4.239	0.01	0.007	0	43.9	41.7	48.2	136	130	0	34	33
2015	7	14	15	4	8	0.784	-0.148	4.236	0.01	0.007	0	43.9	40.9	47.7	136	129	0	34	34
2015	7	14	15	14	8	0.748	-0.161	4.236	0.01	0.007	0	43.9	40.4	47.7	136	128	0	34	34
2015	7	14	15	24	8	0.778	-0.108	4.239	0.01	0.007	0	43.9	41.3	49.5	136	129	0	34	33
2015	7	14	15	34	8	0.768	-0.102	4.236	0.013	0.01	0	43.9	40.9	48.6	136	128	0	34	33
2015	7	14	15	44	8	0.748	-0.128	4.232	0.01	0.007	0	43.4	41.3	48.6	136	129	0	35	33
2015	7	14	15	54	8	0.771	-0.125	4.236	0.016	0.013	0	43	40.9	48.6	135	128	0	35	33
2015	7	14	16	4	8	0.745	-0.157	4.232	0.01	0.007	0	43	40.9	47.7	135	128	0	35	33
2015	7	14	16	14	8	0.741	-0.085	4.232	0.01	0.007	0	46.9	43.9	44.3	143	136	0	34	34
2015	7	14	16	24	8	0.758	-0.115	4.232	0.01	0.007	0	44.3	41.7	46	137	131	0	34	34
2015	7	14	16	34	8	0.807	-0.105	4.232	0.01	0.007	0	44.3	40.9	49.9	137	128	0	34	33
2015	7	14	16	44	8	0.669	-0.217	4.232	0.01	0.007	0	45.2	40.4	49.5	139	127	0	34	33
2015	7	14	16	54	8	0.732	-0.154	4.232	0.01	0.007	0	44.3	40.9	50.3	137	128	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	14	17	4	8	0.787	-0.105	4.232	0.016	0.013	0	44.3	40.9	52	137	128	0	34	33
2015	7	14	17	14	8	0.774	-0.138	4.232	0.01	0.007	0	43.4	40.4	47.7	135	127	0	34	33
2015	7	14	17	24	8	0.758	-0.112	4.229	0.01	0.007	0	44.3	40.9	46.4	137	128	0	34	33
2015	7	14	17	34	8	0.741	-0.112	4.232	0.01	0.007	0	44.3	41.3	48.6	137	129	0	34	33
2015	7	14	17	44	8	0.774	-0.105	4.232	0.01	0.007	0	46.9	43.4	48.2	143	135	0	34	34
2015	7	14	17	54	8	0.738	-0.131	4.229	0.01	0.007	0	44.7	41.3	49	138	129	0	34	33
2015	7	14	18	4	8	0.774	-0.115	4.229	0.01	0.007	0	43.9	40.4	50.7	136	127	0	34	33
2015	7	14	18	14	8	0.778	-0.157	4.229	0.016	0.013	0	43.9	40.4	48.6	136	127	0	34	33
2015	7	14	18	24	8	0.774	-0.105	4.229	0.013	0.01	0	43.4	40.4	47.7	135	127	0	34	33
2015	7	14	18	34	8	0.787	-0.128	4.232	0.01	0.007	0	43	40	48.2	135	126	0	35	33
2015	7	14	18	44	8	0.791	-0.115	4.232	0.016	0.013	0	43.4	39.6	52.5	135	126	0	34	34
2015	7	14	18	54	8	0.764	-0.161	4.232	0.013	0.01	0	43	40	55.5	134	126	0	34	33
2015	7	14	19	4	8	0.794	-0.125	4.232	0.01	0.007	0	43.4	39.6	49.5	135	126	0	34	34
2015	7	14	19	14	8	0.781	-0.138	4.229	0.013	0.01	0	43.4	39.6	49.5	135	125	0	34	33
2015	7	14	19	24	8	0.807	-0.138	4.232	0.01	0.007	0	43.4	40	51.2	135	127	0	34	34
2015	7	14	19	34	8	0.768	-0.082	4.232	0.01	0.007	0	43.9	40	52	136	127	0	34	34
2015	7	14	19	44	8	0.807	-0.112	4.232	0.01	0.007	0	43.4	40	52.5	135	126	0	34	33
2015	7	14	19	54	8	0.774	-0.102	4.232	0.01	0.007	0	43.4	40.4	53.8	135	127	0	34	33
2015	7	14	20	4	8	0.758	-0.072	4.232	0.01	0.007	0	43.4	40.4	51.2	135	127	0	34	33
2015	7	14	20	14	8	0.784	-0.108	4.232	0.01	0.007	0	43.9	40	52	136	127	0	34	34
2015	7	14	20	24	8	0.784	-0.141	4.232	0.01	0.007	0	43.9	40	49.9	136	127	0	34	34
2015	7	14	20	34	8	0.761	-0.098	4.232	0.013	0.01	0	43.9	40.4	51.2	136	128	0	34	34
2015	7	14	20	44	8	0.781	-0.095	4.232	0.01	0.007	0	43.9	40	51.2	136	127	0	34	34
2015	7	14	20	54	8	0.758	-0.085	4.232	0.01	0.007	0	44.3	40.9	50.3	137	129	0	34	34
2015	7	14	21	4	8	0.741	-0.092	4.232	0.01	0.007	0	44.3	40.9	49.5	137	129	0	34	34
2015	7	14	21	14	8	0.761	-0.098	4.229	0.01	0.007	0	43.9	41.3	47.3	137	129	0	35	33
2015	7	14	21	24	8	0.771	-0.095	4.232	0.013	0.01	0	44.3	41.3	49.5	138	129	0	35	33
2015	7	14	21	34	8	0.771	-0.079	4.229	0.01	0.007	0	44.3	41.3	49	137	129	0	34	33
2015	7	14	21	44	8	0.758	-0.085	4.232	0.01	0.007	0	43.9	40.9	52.9	136	128	0	34	33
2015	7	14	21	54	8	0.801	-0.092	4.232	0.01	0.007	0	43.9	40.4	52	136	127	0	34	33
2015	7	14	22	4	8	0.768	-0.082	4.232	0.016	0.013	0	43.9	40	53.8	136	127	0	34	34
2015	7	14	22	14	8	0.748	-0.098	4.236	0.013	0.01	0	43.4	40.4	52	135	126	0	34	32
2015	7	14	22	24	8	0.768	-0.115	4.236	0.01	0.007	0	43.4	40	50.7	135	126	0	34	33
2015	7	14	22	34	8	0.781	-0.082	4.236	0.01	0.007	0	43.9	40.4	60.6	136	127	0	34	33
2015	7	14	22	44	8	0.771	-0.098	4.236	0.01	0.007	0	43.4	40.4	65.8	135	127	0	34	33
2015	7	14	22	54	8	0.745	-0.098	4.236	0.01	0.007	0	43.4	40.4	69.7	135	127	0	34	33
2015	7	14	23	4	8	0.774	-0.098	4.236	0.01	0.007	0	43.9	40.4	70.1	136	127	0	34	33
2015	7	14	23	14	8	0.801	-0.095	4.236	0.01	0.007	0	43.4	40	69.7	135	127	0	34	34
2015	7	14	23	24	8	0.761	-0.098	4.236	0.01	0.007	0	43.9	40	68.8	136	127	0	34	34
2015	7	14	23	34	8	0.755	-0.089	4.236	0.01	0.007	0	44.3	40.9	68.4	137	128	0	34	33
2015	7	14	23	44	8	0.774	-0.082	4.236	0.013	0.01	0	43.4	40.4	70.1	136	127	0	35	33
2015	7	14	23	54	8	0.758	-0.085	4.236	0.01	0.007	0	43.9	40.9	69.7	136	128	0	34	33
2015	7	15	0	4	8	0.774	-0.089	4.236	0.01	0.007	0	43.4	40.4	69.7	136	127	0	35	33
2015	7	15	0	14	8	0.814	-0.056	4.236	0.01	0.007	0	43.4	40.9	70.1	136	128	0	35	33
2015	7	15	0	24	8	0.794	-0.095	4.236	0.01	0.007	0	43	40	69.7	135	126	0	35	33
2015	7	15	0	34	8	0.751	-0.085	4.236	0.01	0.007	0	43.4	40.4	69.2	135	127	0	34	33
2015	7	15	0	44	8	0.781	-0.095	4.239	0.01	0.007	0	43.4	40.4	70.5	135	127	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	15	0	54	8	0.784	-0.102	4.239	0.01	0.007	0	43	40	70.5	135	126	0	35	33
2015	7	15	1	4	8	0.735	-0.052	4.239	0.01	0.007	0	43.9	40.9	70.1	136	128	0	34	33
2015	7	15	1	14	8	0.771	-0.095	4.239	0.01	0.007	0	43.9	40.4	70.5	136	127	0	34	33
2015	7	15	1	24	8	0.738	-0.066	4.239	0.013	0.01	0	44.3	41.3	70.5	137	129	0	34	33
2015	7	15	1	34	8	0.791	-0.069	4.239	0.01	0.007	0	43.4	40.4	69.2	135	127	0	34	33
2015	7	15	1	44	8	0.787	-0.066	4.239	0.01	0.007	0	43.9	40.9	70.5	136	127	0	34	32
2015	7	15	1	54	8	0.751	-0.075	4.239	0.013	0.01	0	43.4	40	71	135	127	0	34	34
2015	7	15	2	4	8	0.764	-0.098	4.239	0.01	0.007	0	43.4	40.4	70.5	135	127	0	34	33
2015	7	15	2	14	8	0.755	-0.066	4.239	0.01	0.007	0	43.4	40.9	71	135	127	0	34	32
2015	7	15	2	24	8	0.748	-0.062	4.239	0.013	0.01	0	43.9	40.9	70.5	136	128	0	34	33
2015	7	15	2	34	8	0.748	-0.079	4.239	0.01	0.007	0	43.4	40.4	70.1	135	127	0	34	33
2015	7	15	2	44	8	0.784	-0.085	4.239	0.013	0.01	0	43.9	40.9	70.5	136	128	0	34	33
2015	7	15	2	54	8	0.748	-0.062	4.239	0.01	0.007	0	43.9	40.4	70.1	135	127	0	33	33
2015	7	15	3	4	8	0.764	-0.082	4.239	0.01	0.007	0	43.9	40.4	67.5	136	127	0	34	33
2015	7	15	3	14	8	0.787	-0.105	4.239	0.01	0.007	0	43.4	40.4	71	135	127	0	34	33
2015	7	15	3	24	8	0.778	-0.069	4.239	0.01	0.007	0	43.4	40.4	71	135	127	0	34	33
2015	7	15	3	34	8	0.758	-0.079	4.239	0.013	0.01	0	43.4	40.4	71	135	127	0	34	33
2015	7	15	3	44	8	0.774	-0.079	4.239	0.01	0.007	0	43	39.6	70.5	134	126	0	34	34
2015	7	15	3	54	8	0.774	-0.052	4.239	0.01	0.007	0	43.4	40.4	70.5	135	127	0	34	33
2015	7	15	4	4	8	0.745	-0.075	4.239	0.01	0.007	0	43.4	40.4	70.1	136	127	0	35	33
2015	7	15	4	14	8	0.794	-0.085	4.239	0.01	0.007	0	43	40	68.4	135	126	0	35	33
2015	7	15	4	24	8	0.741	-0.069	4.239	0.01	0.007	0	43.9	40.9	70.1	136	128	0	34	33
2015	7	15	4	34	8	0.791	-0.089	4.239	0.01	0.007	0	43	40	70.5	134	126	0	34	33
2015	7	15	4	44	8	0.781	-0.082	4.239	0.01	0.007	0	43.4	40.4	70.1	135	127	0	34	33
2015	7	15	4	54	8	0.794	-0.095	4.239	0.01	0.007	0	43.9	40.9	69.7	136	128	0	34	33
2015	7	15	5	4	8	0.768	-0.092	4.239	0.016	0.013	0	43.9	40.4	69.7	136	127	0	34	33
2015	7	15	5	14	8	0.787	-0.062	4.239	0.013	0.01	0	43	40.4	69.7	135	127	0	35	33
2015	7	15	5	24	8	0.768	-0.118	4.239	0.01	0.007	0	43.9	40.4	69.7	136	127	0	34	33
2015	7	15	5	34	8	0.791	-0.098	4.239	0.01	0.007	0	43	40.4	69.7	135	127	0	35	33
2015	7	15	5	44	8	0.778	-0.075	4.239	0.01	0.007	0	44.3	41.3	69.7	137	129	0	34	33
2015	7	15	5	54	8	0.771	-0.066	4.239	0.01	0.007	0	44.3	40.9	69.2	137	128	0	34	33
2015	7	15	6	4	8	0.771	-0.075	4.239	0.01	0.007	0	43.4	40	69.7	136	127	0	35	34
2015	7	15	6	14	8	0.778	-0.098	4.239	0.01	0.007	0	43	40	69.7	135	126	0	35	33
2015	7	15	6	24	8	0.741	-0.056	4.239	0.01	0.007	0	43	39.6	69.7	134	126	0	34	34
2015	7	15	6	34	8	0.791	-0.062	4.239	0.01	0.007	0	43.9	40.4	68.8	136	127	0	34	33
2015	7	15	6	44	8	0.764	-0.072	4.239	0.01	0.007	0	42.6	40	69.2	134	126	0	35	33
2015	7	15	6	54	8	0.764	-0.066	4.239	0.01	0.007	0	43	40.4	69.7	135	127	0	35	33
2015	7	15	7	4	8	0.784	-0.043	4.239	0.01	0.007	0	43	39.6	69.7	134	126	0	34	34
2015	7	15	7	14	8	0.764	-0.098	4.239	0.01	0.007	0	42.1	39.1	69.7	133	125	0	35	34
2015	7	15	7	24	8	0.745	-0.085	4.239	0.01	0.007	0	43	39.6	69.2	134	125	0	34	33
2015	7	15	7	34	8	0.755	-0.108	4.239	0.01	0.007	0	42.1	39.6	69.7	133	125	0	35	33
2015	7	15	7	44	8	0.771	-0.072	4.239	0.013	0.01	0	43	40	69.7	134	126	0	34	33
2015	7	15	7	54	8	0.784	-0.098	4.239	0.01	0.007	0	43	40	69.2	134	126	0	34	33
2015	7	15	8	4	8	0.768	-0.105	4.239	0.013	0.01	0	43	40	69.2	134	126	0	34	33
2015	7	15	8	14	8	0.751	-0.082	4.239	0.01	0.007	0	42.6	40	69.7	134	126	0	35	33
2015	7	15	8	24	8	0.784	-0.098	4.239	0.013	0.01	0	43	40	69.7	134	126	0	34	33
2015	7	15	8	34	8	0.755	-0.092	4.236	0.01	0.007	0	43	40	68.8	134	126	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	15	8	44	8	0.804	-0.092	4.239	0.01	0.007	0	42.1	39.1	69.7	133	125	0	35	34
2015	7	15	8	54	8	0.764	-0.098	4.239	0.01	0.007	0	42.6	39.6	70.1	133	125	0	34	33
2015	7	15	9	4	8	0.745	-0.125	4.236	0.01	0.007	0	42.1	40	70.1	134	126	0	36	33
2015	7	15	9	14	8	0.784	-0.141	4.236	0.01	0.007	0	42.6	39.6	70.1	133	125	0	34	33
2015	7	15	9	24	8	0.768	-0.108	4.236	0.01	0.007	0	42.6	40	65.4	134	126	0	35	33
2015	7	15	9	34	8	0.755	-0.125	4.236	0.01	0.007	0	43	40	71	134	126	0	34	33
2015	7	15	9	44	8	0.758	-0.098	4.236	0.013	0.01	0	43	40	70.5	134	126	0	34	33
2015	7	15	9	54	8	0.755	-0.125	4.236	0.013	0.01	0	42.6	39.6	69.7	133	126	0	34	34
2015	7	15	10	4	8	0.764	-0.138	4.236	0.013	0.01	0	42.6	39.1	67.1	133	125	0	34	34
2015	7	15	10	14	8	0.764	-0.144	4.236	0.01	0.007	0	42.6	39.6	68.8	133	125	0	34	33
2015	7	15	10	24	8	0.768	-0.118	4.236	0.01	0.007	0	43	40	67.5	134	126	0	34	33
2015	7	15	10	34	8	0.781	-0.128	4.236	0.01	0.007	0	42.6	39.6	67.1	133	125	0	34	33
2015	7	15	10	44	8	0.768	-0.131	4.236	0.01	0.007	0	43	40	69.7	133	126	0	33	33
2015	7	15	10	54	8	0.745	-0.098	4.236	0.01	0.007	0	42.6	40	70.5	134	126	0	35	33
2015	7	15	11	4	8	0.774	-0.164	4.236	0.013	0.01	0	42.6	39.6	62.8	133	125	0	34	33
2015	7	15	11	14	8	0.758	-0.148	4.236	0.013	0.01	0	43	40	68.4	134	126	0	34	33
2015	7	15	11	24	8	0.784	-0.108	4.236	0.01	0.007	0	42.6	39.1	61.5	133	125	0	34	34
2015	7	15	11	34	8	0.755	-0.105	4.236	0.01	0.007	0	43	40	65.8	134	126	0	34	33
2015	7	15	11	44	8	0.764	-0.171	4.232	0.01	0.007	0	42.1	39.6	58.9	132	125	0	34	33
2015	7	15	11	54	8	0.768	-0.167	4.232	0.01	0.007	0	42.1	39.1	60.6	132	124	0	34	33
2015	7	15	12	4	8	0.787	-0.138	4.232	0.013	0.01	0	42.6	39.1	54.6	133	124	0	34	33
2015	7	15	12	14	8	0.748	-0.138	4.232	0.01	0.007	0	42.6	39.1	56.8	133	125	0	34	34
2015	7	15	12	24	8	0.768	-0.164	4.232	0.01	0.007	0	42.6	39.6	52.9	133	125	0	34	33
2015	7	15	12	34	8	0.768	-0.148	4.232	0.01	0.007	0	41.7	39.6	60.6	132	125	0	35	33
2015	7	15	12	44	8	0.771	-0.112	4.232	0.013	0.01	0	42.6	39.6	53.3	133	125	0	34	33
2015	7	15	12	54	8	0.774	-0.131	4.232	0.013	0.01	0	42.1	39.1	53.3	132	125	0	34	34
2015	7	15	13	4	8	0.751	-0.115	4.229	0.01	0.007	0	42.6	39.6	50.7	133	125	0	34	33
2015	7	15	13	14	8	0.745	-0.148	4.229	0.013	0.01	0	42.1	39.1	63.6	132	124	0	34	33
2015	7	15	13	24	8	0.761	-0.131	4.229	0.01	0.007	0	42.6	39.6	50.3	133	125	0	34	33
2015	7	15	13	34	8	0.755	-0.171	4.226	0.01	0.007	0	42.6	39.6	55.9	133	124	0	34	32
2015	7	15	13	44	8	0.732	-0.177	4.226	0.013	0.01	0	42.6	39.6	55.5	133	125	0	34	33
2015	7	15	13	54	8	0.764	-0.161	4.229	0.01	0.007	0	42.1	39.6	61.9	133	125	0	35	33
2015	7	15	14	4	8	0.758	-0.144	4.226	0.01	0.007	0	42.6	39.6	55	133	125	0	34	33
2015	7	15	14	14	8	0.748	-0.144	4.222	0.013	0.01	0	42.6	39.6	47.3	133	125	0	34	33
2015	7	15	14	24	8	0.755	-0.171	4.226	0.01	0.007	0	43	40	48.6	134	126	0	34	33
2015	7	15	14	34	8	0.751	-0.115	4.222	0.013	0.01	0	42.6	39.6	52	133	125	0	34	33
2015	7	15	14	44	8	0.781	-0.089	4.219	0.013	0.01	0	43.4	40.4	48.2	135	127	0	34	33
2015	7	15	14	54	8	0.758	-0.141	4.222	0.016	0.013	0	42.6	39.6	47.3	134	125	0	35	33
2015	7	15	15	4	8	0.748	-0.164	4.222	0.013	0.01	0	43.9	40.9	47.7	136	128	0	34	33
2015	7	15	15	14	8	0.741	-0.138	4.222	0.01	0.007	0	43.4	40.4	46.4	135	127	0	34	33
2015	7	15	15	24	8	0.712	-0.135	4.219	0.016	0.013	0	43.4	40.4	48.2	135	127	0	34	33
2015	7	15	15	34	8	0.732	-0.154	4.219	0.01	0.007	0	43.9	40.9	46.9	136	128	0	34	33
2015	7	15	15	44	8	0.791	-0.131	4.216	0.013	0.01	0	43.4	40.4	50.7	135	127	0	34	33
2015	7	15	15	54	8	0.738	-0.154	4.216	0.01	0.007	0	43.9	41.7	47.3	137	129	0	35	32
2015	7	15	16	4	8	0.745	-0.082	4.219	0.01	0.007	0	43.4	40.4	48.2	135	127	0	34	33
2015	7	15	16	14	8	0.774	-0.115	4.216	0.01	0.007	0	43.4	40.9	49	135	128	0	34	33
2015	7	15	16	24	8	0.758	-0.115	4.216	0.013	0.01	0	43.9	40.9	48.6	136	129	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	15	16	34	8	0.741	-0.125	4.216	0.013	0.01	0	43.4	40.9	49.9	135	128	0	34	33
2015	7	15	16	44	8	0.725	-0.154	4.216	0.01	0.007	0	43.4	41.7	48.6	136	130	0	35	33
2015	7	15	16	54	8	0.768	-0.098	4.216	0.01	0.007	0	44.3	41.7	49	137	130	0	34	33
2015	7	15	17	4	8	0.774	-0.144	4.213	0.01	0.007	0	43.4	41.3	49	136	129	0	35	33
2015	7	15	17	14	8	0.758	-0.125	4.213	0.01	0.007	0	44.7	42.6	46	138	131	0	34	32
2015	7	15	17	24	8	0.745	-0.131	4.213	0.01	0.007	0	43.9	41.3	47.7	136	129	0	34	33
2015	7	15	17	34	8	0.758	-0.121	4.213	0.01	0.007	0	43	40.9	47.7	135	128	0	35	33
2015	7	15	17	44	8	0.764	-0.138	4.213	0.013	0.01	0	43.4	41.3	47.7	135	129	0	34	33
2015	7	15	17	54	8	0.761	-0.148	4.213	0.01	0.007	0	43.4	40.9	48.6	135	128	0	34	33
2015	7	15	18	4	8	0.732	-0.131	4.213	0.01	0.007	0	42.6	40.4	48.6	133	128	0	34	34
2015	7	15	18	14	8	0.791	-0.135	4.209	0.01	0.007	0	42.1	40.9	47.7	132	128	0	34	33
2015	7	15	18	24	8	0.748	-0.184	4.213	0.01	0.007	0	42.1	40.4	46.9	132	127	0	34	33
2015	7	15	18	34	8	0.778	-0.118	4.209	0.013	0.01	0	41.7	40	49	131	126	0	34	33
2015	7	15	18	44	8	0.745	-0.131	4.209	0.013	0.01	0	42.1	40.4	46	132	127	0	34	33
2015	7	15	18	54	8	0.774	-0.138	4.209	0.01	0.007	0	42.1	40	49.5	132	126	0	34	33
2015	7	15	19	4	8	0.755	-0.138	4.209	0.016	0.016	0	42.1	40.4	49.9	132	127	0	34	33
2015	7	15	19	14	8	0.758	-0.131	4.206	0.01	0.007	0	42.1	40.4	50.7	132	126	0	34	32
2015	7	15	19	24	8	0.774	-0.118	4.209	0.01	0.007	0	42.6	40.4	51.6	133	127	0	34	33
2015	7	15	19	34	8	0.794	-0.131	4.209	0.013	0.01	0	42.1	40.4	51.6	132	127	0	34	33
2015	7	15	19	44	8	0.758	-0.098	4.209	0.01	0.007	0	42.1	40.4	52.5	132	127	0	34	33
2015	7	15	19	54	8	0.787	-0.148	4.209	0.01	0.007	0	42.1	40	51.6	132	126	0	34	33
2015	7	15	20	4	8	0.748	-0.115	4.206	0.013	0.01	0	42.6	40.9	53.3	133	128	0	34	33
2015	7	15	20	14	8	0.771	-0.082	4.206	0.01	0.007	0	42.1	40	58.9	132	127	0	34	34
2015	7	15	20	24	8	0.791	-0.138	4.206	0.01	0.007	0	42.6	40.4	59.3	133	127	0	34	33
2015	7	15	20	34	8	0.758	-0.121	4.206	0.016	0.013	0	43	41.3	56.3	134	129	0	34	33
2015	7	15	20	44	8	0.774	-0.141	4.209	0.01	0.007	0	42.6	40.9	55	134	129	0	35	34
2015	7	15	20	54	8	0.791	-0.085	4.206	0.01	0.007	0	43	41.3	60.6	134	129	0	34	33
2015	7	15	21	4	8	0.761	-0.098	4.206	0.013	0.01	0	43	41.7	57.6	135	130	0	35	33
2015	7	15	21	14	8	0.758	-0.089	4.206	0.01	0.007	0	43	41.3	58.5	133	129	0	33	33
2015	7	15	21	24	8	0.761	-0.108	4.206	0.01	0.007	0	42.6	40.9	58	133	128	0	34	33
2015	7	15	21	34	8	0.791	-0.115	4.206	0.01	0.007	0	42.6	40.9	60.2	133	128	0	34	33
2015	7	15	21	44	8	0.768	-0.115	4.209	0.013	0.01	0	43	41.3	58.9	134	129	0	34	33
2015	7	15	21	54	8	0.745	-0.089	4.209	0.016	0.013	0	42.6	41.3	62.4	133	128	0	34	32
2015	7	15	22	4	8	0.758	-0.075	4.209	0.01	0.007	0	42.6	41.3	64.9	134	129	0	35	33
2015	7	15	22	14	8	0.719	-0.085	4.209	0.01	0.007	0	42.6	41.3	64.1	133	129	0	34	33
2015	7	15	22	24	8	0.738	-0.115	4.209	0.01	0.007	0	42.1	40.9	58	132	128	0	34	33
2015	7	15	22	34	8	0.755	-0.098	4.209	0.01	0.007	0	42.6	41.3	58.9	133	129	0	34	33
2015	7	15	22	44	8	0.748	-0.062	4.209	0.01	0.007	0	42.1	41.3	54.6	132	128	0	34	32
2015	7	15	22	54	8	0.758	-0.098	4.209	0.01	0.007	0	42.1	40.9	58.5	132	128	0	34	33
2015	7	15	23	4	8	0.745	-0.131	4.209	0.01	0.007	0	41.7	40	61.1	131	126	0	34	33
2015	7	15	23	14	8	0.751	-0.066	4.209	0.01	0.007	0	42.6	41.3	65.8	133	129	0	34	33
2015	7	15	23	24	8	0.755	-0.072	4.209	0.01	0.007	0	42.6	40.9	67.1	133	128	0	34	33
2015	7	15	23	34	8	0.758	-0.115	4.209	0.01	0.007	0	42.1	40.9	66.2	132	128	0	34	33
2015	7	15	23	44	8	0.728	-0.105	4.209	0.01	0.007	0	43.4	41.3	67.9	134	129	0	33	33
2015	7	15	23	54	8	0.719	-0.118	4.209	0.01	0.007	0	42.6	40.9	68.8	133	128	0	34	33
2015	7	16	0	4	8	0.771	-0.098	4.209	0.01	0.007	0	42.1	40.9	68.4	132	128	0	34	33
2015	7	16	0	14	8	0.801	-0.075	4.209	0.01	0.007	0	42.6	40.4	68.8	132	127	0	33	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	16	0	24	8	0.768	-0.092	4.209	0.01	0.007	0	42.1	40.9	67.1	132	128	0	34	33
2015	7	16	0	34	8	0.712	-0.082	4.209	0.013	0.01	0	42.6	40.9	68.4	133	128	0	34	33
2015	7	16	0	44	8	0.794	-0.082	4.213	0.01	0.007	0	42.1	40.9	67.9	132	128	0	34	33
2015	7	16	0	54	8	0.755	-0.095	4.213	0.01	0.007	0	42.1	40.4	66.7	132	127	0	34	33
2015	7	16	1	4	8	0.764	-0.112	4.209	0.01	0.007	0	42.1	40	67.9	132	127	0	34	34
2015	7	16	1	14	8	0.728	-0.092	4.213	0.013	0.01	0	42.1	40.4	68.4	132	127	0	34	33
2015	7	16	1	24	8	0.761	-0.082	4.213	0.016	0.013	0	42.1	40.4	61.1	132	127	0	34	33
2015	7	16	1	34	8	0.748	-0.112	4.213	0.01	0.007	0	42.1	40.9	68.8	132	128	0	34	33
2015	7	16	1	44	8	0.741	-0.075	4.213	0.01	0.007	0	42.1	40.9	67.5	132	128	0	34	33
2015	7	16	1	54	8	0.751	-0.085	4.213	0.013	0.01	0	42.1	40.9	65.8	132	128	0	34	33
2015	7	16	2	4	8	0.741	-0.075	4.213	0.013	0.01	0	42.1	40.9	67.9	132	128	0	34	33
2015	7	16	2	14	8	0.745	-0.095	4.213	0.01	0.007	0	42.6	40.9	67.5	133	128	0	34	33
2015	7	16	2	24	8	0.741	-0.092	4.213	0.01	0.007	0	42.1	40.4	67.5	132	127	0	34	33
2015	7	16	2	34	8	0.745	-0.089	4.213	0.013	0.01	0	42.1	40.9	67.5	132	128	0	34	33
2015	7	16	2	44	8	0.745	-0.075	4.213	0.013	0.01	0	42.1	40.4	67.5	132	128	0	34	34
2015	7	16	2	54	8	0.771	-0.115	4.213	0.01	0.007	0	42.1	40.4	67.5	132	127	0	34	33
2015	7	16	3	4	8	0.741	-0.112	4.213	0.01	0.007	0	42.1	40.4	67.5	132	127	0	34	33
2015	7	16	3	14	8	0.768	-0.125	4.213	0.01	0.007	0	42.1	40.4	66.7	132	127	0	34	33
2015	7	16	3	24	8	0.745	-0.079	4.213	0.013	0.01	0	41.7	40.9	67.5	132	128	0	35	33
2015	7	16	3	34	8	0.751	-0.092	4.216	0.01	0.007	0	42.1	40	66.7	132	127	0	34	34
2015	7	16	3	44	8	0.741	-0.108	4.216	0.013	0.01	0	42.6	41.3	66.2	134	129	0	35	33
2015	7	16	3	54	8	0.722	-0.056	4.216	0.013	0.01	0	42.1	40.9	67.1	132	128	0	34	33
2015	7	16	4	4	8	0.702	-0.118	4.216	0.01	0.007	0	42.1	40.9	65.4	132	128	0	34	33
2015	7	16	4	14	8	0.745	-0.092	4.216	0.01	0.007	0	42.1	40.9	65.8	133	128	0	35	33
2015	7	16	4	24	8	0.764	-0.131	4.219	0.013	0.01	0	41.7	40.4	65.8	132	127	0	35	33
2015	7	16	4	34	8	0.781	-0.105	4.222	0.016	0.013	0	42.6	40.4	66.7	132	127	0	33	33
2015	7	16	4	44	8	0.728	-0.098	4.222	0.013	0.01	0	43	41.3	66.2	134	129	0	34	33
2015	7	16	4	54	8	0.755	-0.098	4.222	0.01	0.007	0	43	41.3	66.2	134	129	0	34	33
2015	7	16	5	4	8	0.764	-0.105	4.226	0.01	0.007	0	43	41.3	66.7	134	129	0	34	33
2015	7	16	5	14	8	0.741	-0.121	4.226	0.01	0.007	0	42.6	40.9	66.7	133	128	0	34	33
2015	7	16	5	24	8	0.774	-0.098	4.226	0.013	0.01	0	42.6	41.3	66.7	133	128	0	34	32
2015	7	16	5	34	8	0.745	-0.098	4.226	0.01	0.007	0	42.1	40.9	66.7	133	128	0	35	33
2015	7	16	5	44	8	0.764	-0.082	4.226	0.01	0.007	0	42.6	40.9	66.7	134	128	0	35	33
2015	7	16	5	54	8	0.761	-0.082	4.226	0.01	0.007	0	42.6	40.4	66.7	133	127	0	34	33
2015	7	16	6	4	8	0.741	-0.089	4.226	0.016	0.013	0	43	41.7	67.1	135	130	0	35	33
2015	7	16	6	14	8	0.728	-0.108	4.226	0.013	0.01	0	42.6	41.3	67.1	134	129	0	35	33
2015	7	16	6	24	8	0.738	-0.112	4.226	0.01	0.007	0	42.1	40.4	67.1	133	127	0	35	33
2015	7	16	6	34	8	0.761	-0.092	4.226	0.01	0.007	0	41.7	40.4	67.9	132	127	0	35	33
2015	7	16	6	44	8	0.755	-0.066	4.226	0.01	0.007	0	41.7	39.6	67.5	132	126	0	35	34
2015	7	16	6	54	8	0.735	-0.075	4.226	0.013	0.01	0	42.1	39.6	68.4	132	126	0	34	34
2015	7	16	7	4	8	0.751	-0.098	4.226	0.01	0.007	0	41.7	40	67.5	131	126	0	34	33
2015	7	16	7	14	8	0.748	-0.115	4.226	0.01	0.007	0	41.7	40	67.9	131	126	0	34	33
2015	7	16	7	24	8	0.755	-0.125	4.226	0.01	0.007	0	41.7	40	68.4	131	126	0	34	33
2015	7	16	7	34	8	0.755	-0.105	4.226	0.01	0.007	0	41.7	39.6	68.4	131	125	0	34	33
2015	7	16	7	44	8	0.732	-0.128	4.226	0.01	0.007	0	41.7	39.6	68.4	131	125	0	34	33
2015	7	16	7	54	8	0.771	-0.115	4.226	0.01	0.007	0	41.7	40	67.9	131	126	0	34	33
2015	7	16	8	4	8	0.758	-0.115	4.226	0.01	0.007	0	41.7	39.6	68.4	131	125	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	16	8	14	8	0.781	-0.115	4.226	0.013	0.01	0	41.7	39.6	67.9	132	126	0	35	34
2015	7	16	8	24	8	0.758	-0.112	4.226	0.01	0.007	0	42.1	39.6	67.5	132	126	0	34	34
2015	7	16	8	34	8	0.764	-0.105	4.226	0.016	0.013	0	41.3	39.6	67.5	131	125	0	35	33
2015	7	16	8	44	8	0.771	-0.098	4.226	0.013	0.01	0	42.1	40	68.4	132	126	0	34	33
2015	7	16	8	54	8	0.764	-0.105	4.226	0.01	0.007	0	42.1	40	66.2	132	126	0	34	33
2015	7	16	9	4	8	0.768	-0.141	4.226	0.01	0.007	0	41.3	39.6	66.7	131	126	0	35	34
2015	7	16	9	14	8	0.758	-0.164	4.226	0.01	0.007	0	41.3	39.6	66.7	131	125	0	35	33
2015	7	16	9	24	8	0.735	-0.161	4.222	0.013	0.01	0	41.7	39.6	66.2	131	125	0	34	33
2015	7	16	9	34	8	0.761	-0.148	4.222	0.01	0.007	0	41.7	40	65.4	131	126	0	34	33
2015	7	16	9	44	8	0.751	-0.135	4.219	0.01	0.007	0	41.7	40	65.4	131	126	0	34	33
2015	7	16	9	54	8	0.741	-0.128	4.219	0.01	0.007	0	41.3	40	53.8	131	126	0	35	33
2015	7	16	10	4	8	0.755	-0.148	4.216	0.013	0.01	0	41.3	39.1	60.6	131	125	0	35	34
2015	7	16	10	14	8	0.781	-0.131	4.216	0.01	0.007	0	41.3	40	65.4	131	126	0	35	33
2015	7	16	10	24	8	0.741	-0.161	4.213	0.013	0.01	0	40.9	39.1	58	130	125	0	35	34
2015	7	16	10	34	8	0.778	-0.125	4.213	0.01	0.007	0	40.9	39.6	63.6	130	125	0	35	33
2015	7	16	10	44	8	0.741	-0.131	4.213	0.013	0.01	0	41.3	39.6	61.1	130	125	0	34	33
2015	7	16	10	54	8	0.761	-0.174	4.213	0.016	0.013	0	41.3	39.6	55.5	131	125	0	35	33
2015	7	16	11	4	8	0.745	-0.174	4.209	0.013	0.01	0	40.9	38.7	57.6	129	124	0	34	34
2015	7	16	11	14	8	0.755	-0.148	4.209	0.01	0.007	0	41.3	38.7	61.5	130	124	0	34	34
2015	7	16	11	24	8	0.738	-0.154	4.213	0.01	0.007	0	41.3	39.6	52.9	130	125	0	34	33
2015	7	16	11	34	8	0.741	-0.144	4.209	0.01	0.007	0	41.3	39.1	58.5	130	124	0	34	33
2015	7	16	11	44	8	0.768	-0.148	4.209	0.01	0.007	0	41.3	39.6	55.5	130	125	0	34	33
2015	7	16	11	54	8	0.778	-0.141	4.209	0.01	0.007	0	41.3	39.1	52.9	130	125	0	34	34
2015	7	16	12	4	8	0.735	-0.131	4.209	0.01	0.007	0	42.1	40.4	57.2	132	127	0	34	33
2015	7	16	12	14	8	0.745	-0.18	4.209	0.013	0.01	0	41.3	39.6	58	130	125	0	34	33
2015	7	16	12	24	8	0.758	-0.164	4.206	0.013	0.01	0	41.3	39.1	68.4	130	124	0	34	33
2015	7	16	12	34	8	0.751	-0.135	4.206	0.01	0.007	0	40.9	39.1	59.8	129	125	0	34	34
2015	7	16	12	44	8	0.768	-0.157	4.206	0.01	0.007	0	40.4	39.6	64.5	129	125	0	35	33
2015	7	16	12	54	8	0.748	-0.115	4.206	0.01	0.007	0	41.7	40	61.1	131	126	0	34	33
2015	7	16	13	4	8	0.725	-0.177	4.206	0.01	0.007	0	40.4	39.1	65.4	129	124	0	35	33
2015	7	16	13	14	8	0.728	-0.115	4.206	0.013	0.01	0	41.7	40.4	54.6	131	127	0	34	33
2015	7	16	13	24	8	0.755	-0.154	4.206	0.01	0.007	0	40.9	39.6	52	130	125	0	35	33
2015	7	16	13	34	8	0.771	-0.171	4.206	0.01	0.007	0	40.9	39.6	61.9	130	125	0	35	33
2015	7	16	13	44	8	0.732	-0.154	4.206	0.01	0.007	0	41.3	39.6	54.2	130	125	0	34	33
2015	7	16	13	54	8	0.741	-0.177	4.203	0.01	0.007	0	41.7	39.6	56.8	130	125	0	33	33
2015	7	16	14	4	8	0.735	-0.184	4.203	0.01	0.007	0	40.9	39.6	54.2	130	125	0	35	33
2015	7	16	14	14	8	0.745	-0.157	4.203	0.01	0.007	0	41.3	40	53.3	130	126	0	34	33
2015	7	16	14	24	8	0.738	-0.177	4.203	0.01	0.007	0	41.7	40	53.3	131	126	0	34	33
2015	7	16	14	34	8	0.722	-0.154	4.203	0.013	0.01	0	41.3	39.6	52	130	125	0	34	33
2015	7	16	14	44	8	0.748	-0.161	4.203	0.01	0.007	0	41.7	40	55	131	126	0	34	33
2015	7	16	14	54	8	0.771	-0.161	4.203	0.01	0.007	0	41.3	40	63.2	130	126	0	34	33
2015	7	16	15	4	8	0.768	-0.148	4.203	0.01	0.007	0	41.7	40.4	52.5	131	127	0	34	33
2015	7	16	15	14	8	0.732	-0.187	4.203	0.01	0.007	0	41.7	40	49.9	131	126	0	34	33
2015	7	16	15	24	8	0.741	-0.121	4.203	0.01	0.007	0	41.7	40	47.7	131	126	0	34	33
2015	7	16	15	34	8	0.751	-0.135	4.199	0.01	0.007	0	41.7	40	47.3	131	127	0	34	34
2015	7	16	15	44	8	0.722	-0.151	4.199	0.01	0.007	0	41.7	40	49.5	131	126	0	34	33
2015	7	16	15	54	8	0.725	-0.164	4.199	0.01	0.007	0	43.9	41.3	48.2	136	129	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	16	16	4	8	0.758	-0.157	4.199	0.013	0.01	0	42.6	41.3	50.3	133	128	0	34	32
2015	7	16	16	14	8	0.745	-0.118	4.199	0.01	0.007	0	44.7	41.3	45.6	138	129	0	34	33
2015	7	16	16	24	8	0.761	-0.148	4.196	0.01	0.007	0	44.7	40.9	48.6	138	128	0	34	33
2015	7	16	16	34	8	0.709	-0.128	4.199	0.013	0.01	0	45.6	42.1	52.5	140	131	0	34	33
2015	7	16	16	44	8	0.778	-0.098	4.199	0.01	0.007	0	44.3	40.9	52.5	137	128	0	34	33
2015	7	16	16	54	8	0.761	-0.125	4.196	0.01	0.007	0	43.9	40.9	51.2	136	128	0	34	33
2015	7	16	17	4	8	0.791	-0.148	4.196	0.01	0.007	0	43.4	40.9	49.5	136	128	0	35	33
2015	7	16	17	14	8	0.761	-0.092	4.196	0.01	0.007	0	43.4	40.4	48.6	135	127	0	34	33
2015	7	16	17	24	8	0.758	-0.105	4.196	0.013	0.01	0	44.3	40.9	49	137	128	0	34	33
2015	7	16	17	34	8	0.725	-0.115	4.199	0.013	0.01	0	43.9	41.3	49.5	136	129	0	34	33
2015	7	16	17	44	8	0.758	-0.135	4.193	0.01	0.007	0	43.9	41.3	49.5	137	128	0	35	32
2015	7	16	17	54	8	0.768	-0.115	4.193	0.01	0.007	0	43.4	40.4	49	136	127	0	35	33
2015	7	16	18	4	8	0.761	-0.092	4.193	0.01	0.007	0	43.9	40.4	49	136	127	0	34	33
2015	7	16	18	14	8	0.774	-0.131	4.193	0.01	0.007	0	43.4	40.4	48.6	135	127	0	34	33
2015	7	16	18	24	8	0.758	-0.121	4.196	0.01	0.007	0	43.9	40.9	48.2	136	128	0	34	33
2015	7	16	18	34	8	0.764	-0.105	4.193	0.01	0.007	0	43.9	40.9	47.3	136	128	0	34	33
2015	7	16	18	44	8	0.758	-0.112	4.193	0.016	0.013	0	43.4	40.4	50.3	136	127	0	35	33
2015	7	16	18	54	8	0.774	-0.098	4.196	0.013	0.01	0	43.4	40.4	50.7	135	127	0	34	33
2015	7	16	19	4	8	0.791	-0.115	4.196	0.01	0.007	0	43.9	40.4	51.6	136	127	0	34	33
2015	7	16	19	14	8	0.774	-0.102	4.196	0.01	0.007	0	43.4	40	57.6	135	126	0	34	33
2015	7	16	19	24	8	0.764	-0.115	4.196	0.01	0.007	0	44.3	40.9	52	137	128	0	34	33
2015	7	16	19	34	8	0.758	-0.112	4.196	0.016	0.013	0	43.9	40	57.2	135	126	0	33	33
2015	7	16	19	44	8	0.738	-0.154	4.196	0.01	0.007	0	40.4	40.4	58	128	127	0	34	33
2015	7	16	19	54	8	0.758	-0.138	4.196	0.01	0.007	0	43.4	40.4	55	135	127	0	34	33
2015	7	16	20	4	8	0.758	-0.098	4.196	0.013	0.01	0	43.9	40.9	54.6	136	128	0	34	33
2015	7	16	20	14	8	0.741	-0.092	4.196	0.013	0.01	0	43.9	40.9	53.8	136	128	0	34	33
2015	7	16	20	24	8	0.751	-0.131	4.196	0.013	0.01	0	43.9	40.9	50.3	136	128	0	34	33
2015	7	16	20	34	8	0.761	-0.115	4.196	0.01	0.007	0	43.9	40.9	51.2	136	128	0	34	33
2015	7	16	20	44	8	0.758	-0.098	4.193	0.01	0.007	0	44.3	42.1	51.6	138	130	0	35	32
2015	7	16	20	54	8	0.758	-0.075	4.196	0.01	0.007	0	44.7	41.7	49	138	130	0	34	33
2015	7	16	21	4	8	0.741	-0.115	4.196	0.01	0.007	0	44.3	41.3	51.2	138	129	0	35	33
2015	7	16	21	14	8	0.768	-0.108	4.196	0.01	0.007	0	43.4	40.4	55.5	136	128	0	35	34
2015	7	16	21	24	8	0.748	-0.098	4.196	0.01	0.007	0	44.3	40.4	50.7	137	128	0	34	34
2015	7	16	21	34	8	0.748	-0.082	4.196	0.01	0.007	0	45.6	42.1	53.8	140	131	0	34	33
2015	7	16	21	44	8	0.748	-0.098	4.193	0.013	0.01	0	44.3	41.3	49.5	137	128	0	34	32
2015	7	16	21	54	8	0.761	-0.098	4.193	0.01	0.007	0	44.3	40.4	51.2	137	128	0	34	34
2015	7	16	22	4	8	0.761	-0.092	4.196	0.016	0.013	0	44.3	40.9	62.8	137	128	0	34	33
2015	7	16	22	14	8	0.745	-0.115	4.196	0.01	0.007	0	43.9	40.9	62.4	136	128	0	34	33
2015	7	16	22	24	8	0.761	-0.082	4.196	0.01	0.007	0	43.9	40.9	60.6	136	128	0	34	33
2015	7	16	22	34	8	0.702	-0.075	4.196	0.01	0.007	0	44.3	40.4	69.2	137	128	0	34	34
2015	7	16	22	44	8	0.784	-0.075	4.196	0.01	0.007	0	44.3	40.9	69.2	137	129	0	34	34
2015	7	16	22	54	8	0.735	-0.082	4.196	0.01	0.007	0	44.7	41.3	57.2	138	129	0	34	33
2015	7	16	23	4	8	0.764	-0.066	4.196	0.01	0.007	0	43.9	40.9	66.7	136	128	0	34	33
2015	7	16	23	14	8	0.748	-0.092	4.196	0.01	0.007	0	44.3	41.3	69.2	136	128	0	33	32
2015	7	16	23	24	8	0.768	-0.118	4.199	0.013	0.01	0	43.9	40.4	68.8	136	127	0	34	33
2015	7	16	23	34	8	0.768	-0.102	4.199	0.01	0.007	0	43.9	41.3	69.7	136	128	0	34	32
2015	7	16	23	44	8	0.751	-0.085	4.199	0.01	0.007	0	43.4	40.4	69.7	135	127	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	16	23	54	8	0.771	-0.089	4.199	0.013	0.01	0	43.9	40.9	70.1	136	128	0	34	33
2015	7	17	0	4	8	0.761	-0.075	4.199	0.01	0.007	0	44.3	41.3	69.7	137	128	0	34	32
2015	7	17	0	14	8	0.761	-0.089	4.199	0.01	0.007	0	43.9	41.3	70.5	137	128	0	35	32
2015	7	17	0	24	8	0.751	-0.066	4.199	0.01	0.007	0	44.3	40.9	69.2	137	128	0	34	33
2015	7	17	0	34	8	0.774	-0.098	4.199	0.01	0.007	0	43.9	40.9	69.7	136	128	0	34	33
2015	7	17	0	44	8	0.751	-0.069	4.199	0.013	0.01	0	43.9	41.3	69.2	136	128	0	34	32
2015	7	17	0	54	8	0.781	-0.128	4.199	0.01	0.007	0	43.9	40.9	70.5	136	128	0	34	33
2015	7	17	1	4	8	0.761	-0.072	4.199	0.013	0.01	0	43.9	41.3	69.7	136	128	0	34	32
2015	7	17	1	14	8	0.761	-0.069	4.199	0.01	0.007	0	44.7	41.7	70.5	138	130	0	34	33
2015	7	17	1	24	8	0.778	-0.082	4.199	0.01	0.007	0	44.7	41.7	69.7	138	130	0	34	33
2015	7	17	1	34	8	0.781	-0.095	4.199	0.01	0.007	0	43.4	40.9	69.7	135	128	0	34	33
2015	7	17	1	44	8	0.745	-0.066	4.199	0.013	0.01	0	44.7	41.7	70.5	138	130	0	34	33
2015	7	17	1	54	8	0.755	-0.105	4.199	0.013	0.01	0	44.3	41.3	71	137	129	0	34	33
2015	7	17	2	4	8	0.748	-0.082	4.199	0.01	0.007	0	44.3	41.3	70.1	137	129	0	34	33
2015	7	17	2	14	8	0.774	-0.085	4.199	0.01	0.007	0	44.3	41.3	71.4	137	129	0	34	33
2015	7	17	2	24	8	0.745	-0.108	4.199	0.01	0.007	0	44.3	41.3	59.3	137	129	0	34	33
2015	7	17	2	34	8	0.741	-0.092	4.199	0.01	0.007	0	43.9	40.9	67.9	136	128	0	34	33
2015	7	17	2	44	8	0.748	-0.066	4.199	0.01	0.007	0	44.7	41.7	71	138	130	0	34	33
2015	7	17	2	54	8	0.764	-0.082	4.199	0.01	0.007	0	44.3	40.4	70.5	137	128	0	34	34
2015	7	17	3	4	8	0.764	-0.095	4.199	0.01	0.007	0	43.9	40.9	71	136	128	0	34	33
2015	7	17	3	14	8	0.745	-0.098	4.199	0.01	0.007	0	43.9	40.9	71.4	136	128	0	34	33
2015	7	17	3	24	8	0.761	-0.066	4.199	0.01	0.007	0	44.3	41.3	71	138	129	0	35	33
2015	7	17	3	34	8	0.794	-0.092	4.199	0.01	0.007	0	43.9	41.3	71	136	128	0	34	32
2015	7	17	3	44	8	0.741	-0.105	4.199	0.016	0.013	0	44.7	41.3	71	138	129	0	34	33
2015	7	17	3	54	8	0.735	-0.098	4.199	0.016	0.013	0	44.3	40.9	70.5	137	128	0	34	33
2015	7	17	4	4	8	0.758	-0.098	4.199	0.01	0.007	0	44.3	40.9	70.5	137	129	0	34	34
2015	7	17	4	14	8	0.702	-0.082	4.199	0.01	0.007	0	44.7	41.3	70.5	138	129	0	34	33
2015	7	17	4	24	8	0.735	-0.092	4.199	0.01	0.007	0	43.9	40.9	70.1	137	128	0	35	33
2015	7	17	4	34	8	0.712	-0.085	4.199	0.01	0.007	0	44.3	40.4	71	137	128	0	34	34
2015	7	17	4	44	8	0.745	-0.075	4.199	0.01	0.007	0	44.7	41.3	70.5	138	129	0	34	33
2015	7	17	4	54	8	0.745	-0.059	4.199	0.01	0.007	0	44.7	41.3	70.5	138	129	0	34	33
2015	7	17	5	4	8	0.725	-0.079	4.199	0.013	0.01	0	44.7	41.3	70.1	138	129	0	34	33
2015	7	17	5	14	8	0.751	-0.102	4.199	0.01	0.007	0	44.7	41.3	70.5	138	129	0	34	33
2015	7	17	5	24	8	0.732	-0.095	4.199	0.01	0.007	0	44.3	41.3	70.1	137	129	0	34	33
2015	7	17	5	34	8	0.741	-0.082	4.199	0.01	0.007	0	44.7	41.7	69.7	138	130	0	34	33
2015	7	17	5	44	8	0.764	-0.066	4.199	0.01	0.007	0	43.9	40.4	70.5	137	128	0	35	34
2015	7	17	5	54	8	0.728	-0.075	4.199	0.013	0.01	0	44.7	41.3	71	137	128	0	33	32
2015	7	17	6	4	8	0.771	-0.098	4.199	0.01	0.007	0	43.9	41.3	70.5	136	128	0	34	32
2015	7	17	6	14	8	0.768	-0.092	4.199	0.016	0.013	0	43.9	40.4	71	136	128	0	34	34
2015	7	17	6	24	8	0.732	-0.079	4.199	0.01	0.007	0	43.9	40.9	70.5	136	128	0	34	33
2015	7	17	6	34	8	0.771	-0.105	4.199	0.013	0.01	0	43.4	40.4	71	135	127	0	34	33
2015	7	17	6	44	8	0.735	-0.098	4.199	0.01	0.007	0	44.3	40.9	71	137	128	0	34	33
2015	7	17	6	54	8	0.764	-0.079	4.199	0.01	0.007	0	43.9	40.4	70.1	136	127	0	34	33
2015	7	17	7	4	8	0.781	-0.079	4.199	0.01	0.007	0	43	40	70.5	135	127	0	35	34
2015	7	17	7	14	8	0.738	-0.095	4.199	0.013	0.01	0	43.4	40.4	71	135	127	0	34	33
2015	7	17	7	24	8	0.774	-0.079	4.199	0.01	0.007	0	43	40.4	70.5	135	127	0	35	33
2015	7	17	7	34	8	0.755	-0.082	4.196	0.013	0.01	0	43.4	40.4	70.5	135	127	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	17	7	44	8	0.761	-0.118	4.199	0.01	0.007	0	43	40	70.5	134	126	0	34	33
2015	7	17	7	54	8	0.725	-0.095	4.199	0.01	0.007	0	43.4	40.4	70.5	135	127	0	34	33
2015	7	17	8	4	8	0.755	-0.098	4.196	0.01	0.007	0	43	40.4	70.5	135	127	0	35	33
2015	7	17	8	14	8	0.751	-0.102	4.196	0.01	0.007	0	43.4	40.4	70.5	135	127	0	34	33
2015	7	17	8	24	8	0.764	-0.066	4.196	0.01	0.007	0	43.9	40.9	70.5	136	128	0	34	33
2015	7	17	8	34	8	0.741	-0.089	4.196	0.013	0.01	0	43.4	40.4	71	136	128	0	35	34
2015	7	17	8	44	8	0.748	-0.089	4.196	0.013	0.01	0	43.4	40	71.4	136	127	0	35	34
2015	7	17	8	54	8	0.745	-0.069	4.196	0.01	0.007	0	43.9	40	71	136	127	0	34	34
2015	7	17	9	4	8	0.774	-0.089	4.196	0.01	0.007	0	43.9	40.9	71	136	128	0	34	33
2015	7	17	9	14	8	0.755	-0.079	4.196	0.01	0.007	0	43.9	40.4	71	136	127	0	34	33
2015	7	17	9	24	8	0.755	-0.098	4.196	0.01	0.007	0	43.9	40.9	71	136	128	0	34	33
2015	7	17	9	34	8	0.748	-0.128	4.196	0.013	0.01	0	43	40.4	70.5	135	127	0	35	33
2015	7	17	9	44	8	0.745	-0.131	4.196	0.01	0.007	0	43	40.4	67.1	135	127	0	35	33
2015	7	17	9	54	8	0.771	-0.108	4.196	0.01	0.007	0	43.4	40.4	68.8	135	127	0	34	33
2015	7	17	10	4	8	0.751	-0.141	4.196	0.01	0.007	0	43	40	70.5	134	126	0	34	33
2015	7	17	10	14	8	0.771	-0.131	4.196	0.01	0.007	0	43	40.4	70.5	135	127	0	35	33
2015	7	17	10	24	8	0.771	-0.151	4.196	0.01	0.007	0	43.4	40.4	69.2	135	127	0	34	33
2015	7	17	10	34	8	0.725	-0.148	4.196	0.01	0.007	0	43	40	70.1	135	127	0	35	34
2015	7	17	10	44	8	0.738	-0.128	4.193	0.01	0.007	0	43.4	40	69.2	135	127	0	34	34
2015	7	17	10	54	8	0.755	-0.164	4.193	0.01	0.007	0	42.6	39.6	56.3	134	125	0	35	33
2015	7	17	11	4	8	0.781	-0.144	4.193	0.013	0.01	0	43	39.6	55.9	134	126	0	34	34
2015	7	17	11	14	8	0.771	-0.144	4.193	0.01	0.007	0	43	40	59.3	134	126	0	34	33
2015	7	17	11	24	8	0.774	-0.161	4.19	0.013	0.01	0	43	40	55	134	126	0	34	33
2015	7	17	11	34	8	0.778	-0.135	4.193	0.01	0.007	0	42.6	39.6	63.6	134	125	0	35	33
2015	7	17	11	44	8	0.751	-0.167	4.19	0.016	0.013	0	43	40	63.2	134	126	0	34	33
2015	7	17	11	54	8	0.732	-0.115	4.186	0.013	0.01	0	42.6	40	52	134	126	0	35	33
2015	7	17	12	4	8	0.738	-0.19	4.186	0.01	0.007	0	43	40	49	134	126	0	34	33
2015	7	17	12	14	8	0.741	-0.144	4.183	0.01	0.007	0	42.6	39.6	49.9	134	126	0	35	34
2015	7	17	12	24	8	0.725	-0.151	4.186	0.01	0.007	0	43	40.4	49.9	135	126	0	35	32
2015	7	17	12	34	8	0.741	-0.144	4.183	0.01	0.007	0	43.4	40.4	46.4	135	127	0	34	33
2015	7	17	12	44	8	0.758	-0.171	4.18	0.01	0.007	0	43.9	40.4	49	136	127	0	34	33
2015	7	17	12	54	8	0.751	-0.108	4.183	0.013	0.01	0	43.4	40.4	48.6	135	127	0	34	33
2015	7	17	13	4	8	0.758	-0.167	4.18	0.013	0.01	0	44.3	40.9	51.6	137	128	0	34	33
2015	7	17	13	14	8	0.725	-0.161	4.18	0.01	0.007	0	43.4	40.9	50.3	136	128	0	35	33
2015	7	17	13	24	8	0.745	-0.115	4.177	0.016	0.013	0	43.4	40.4	51.2	136	127	0	35	33
2015	7	17	13	34	8	0.758	-0.138	4.177	0.013	0.01	0	44.3	41.3	51.2	137	129	0	34	33
2015	7	17	13	44	8	0.722	-0.079	4.177	0.01	0.007	0	44.3	40.9	49	137	128	0	34	33
2015	7	17	13	54	8	0.735	-0.148	4.177	0.01	0.007	0	44.7	41.7	49	138	130	0	34	33
2015	7	17	14	4	8	0.745	-0.102	4.177	0.016	0.013	0	44.7	41.7	47.3	138	130	0	34	33
2015	7	17	14	14	8	0.768	-0.092	4.173	0.013	0.01	0	44.7	41.7	49.5	138	130	0	34	33
2015	7	17	14	24	8	0.735	-0.075	4.173	0.01	0.007	0	44.3	41.7	51.2	138	130	0	35	33
2015	7	17	14	34	8	0.728	-0.125	4.17	0.013	0.01	0	44.7	40.9	46.9	138	129	0	34	34
2015	7	17	14	44	8	0.741	-0.118	4.167	0.01	0.007	0	43.9	41.3	49.5	137	129	0	35	33
2015	7	17	14	54	8	0.728	-0.128	4.17	0.01	0.007	0	44.7	41.7	48.2	138	130	0	34	33
2015	7	17	15	4	8	0.728	-0.121	4.167	0.01	0.007	0	44.7	41.7	49.9	139	131	0	35	34
2015	7	17	15	14	8	0.722	-0.135	4.167	0.01	0.007	0	45.6	42.1	50.3	140	131	0	34	33
2015	7	17	15	24	8	0.709	-0.075	4.167	0.016	0.016	0	45.6	42.6	44.7	140	131	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	17	15	34	8	0.748	-0.115	4.167	0.01	0.007	0	46.4	43.4	47.3	142	134	0	34	33
2015	7	17	15	44	8	0.758	-0.171	4.167	0.01	0.007	0	44.3	41.7	51.2	137	130	0	34	33
2015	7	17	15	54	8	0.784	-0.069	4.163	0.01	0.007	0	48.6	45.6	47.3	147	139	0	34	33
2015	7	17	16	4	8	0.735	-0.108	4.163	0.013	0.01	0	44.7	41.7	49	138	130	0	34	33
2015	7	17	16	14	8	0.728	-0.164	4.16	0.01	0.007	0	44.7	42.1	47.3	138	131	0	34	33
2015	7	17	16	24	8	0.745	-0.102	4.16	0.01	0.007	0	45.2	42.1	49	139	131	0	34	33
2015	7	17	16	34	8	0.755	-0.105	4.163	0.013	0.01	0	44.3	41.3	49.5	137	129	0	34	33
2015	7	17	16	44	8	0.725	-0.102	4.16	0.01	0.007	0	44.3	41.3	51.2	137	129	0	34	33
2015	7	17	16	54	8	0.738	-0.112	4.16	0.01	0.007	0	44.3	41.7	49.5	137	129	0	34	32
2015	7	17	17	4	8	0.768	-0.082	4.16	0.01	0.007	0	44.7	42.1	49.5	138	131	0	34	33
2015	7	17	17	14	8	0.712	-0.141	4.157	0.016	0.013	0	46	43.4	48.6	141	134	0	34	33
2015	7	17	17	24	8	0.735	-0.098	4.157	0.01	0.007	0	43.9	40.9	49.5	137	129	0	35	34
2015	7	17	17	34	8	0.751	-0.085	4.154	0.01	0.007	0	44.3	41.7	49	137	130	0	34	33
2015	7	17	17	44	8	0.741	-0.115	4.157	0.013	0.01	0	44.3	41.3	49.9	137	129	0	34	33
2015	7	17	17	54	8	0.761	-0.115	4.157	0.01	0.007	0	44.7	41.7	49.5	138	131	0	34	34
2015	7	17	18	4	8	0.722	-0.089	4.157	0.013	0.01	0	43.9	41.7	50.7	137	129	0	35	32
2015	7	17	18	14	8	0.745	-0.102	4.154	0.013	0.01	0	44.7	41.7	50.3	138	130	0	34	33
2015	7	17	18	24	8	0.751	-0.075	4.154	0.016	0.013	0	45.2	42.1	49.9	139	131	0	34	33
2015	7	17	18	34	8	0.715	-0.079	4.154	0.013	0.01	0	44.7	41.7	47.3	138	130	0	34	33
2015	7	17	18	44	8	0.751	-0.075	4.154	0.016	0.013	0	44.3	42.1	49.5	137	130	0	34	32
2015	7	17	18	54	8	0.741	-0.102	4.154	0.01	0.007	0	44.3	41.3	54.2	137	129	0	34	33
2015	7	17	19	4	8	0.755	-0.079	4.15	0.016	0.013	0	43.9	40.9	51.2	136	128	0	34	33
2015	7	17	19	14	8	0.725	-0.066	4.15	0.01	0.007	0	44.7	41.3	50.7	138	130	0	34	34
2015	7	17	19	24	8	0.735	-0.108	4.15	0.016	0.013	0	44.3	41.7	51.2	137	129	0	34	32
2015	7	17	19	34	8	0.735	-0.098	4.15	0.01	0.007	0	44.3	41.3	67.1	137	129	0	34	33
2015	7	17	19	44	8	0.735	-0.075	4.15	0.013	0.01	0	44.3	40.9	64.5	137	129	0	34	34
2015	7	17	19	54	8	0.732	-0.082	4.15	0.01	0.007	0	43.9	41.3	66.2	137	129	0	35	33
2015	7	17	20	4	8	0.735	-0.085	4.15	0.01	0.007	0	44.3	41.7	57.6	138	130	0	35	33
2015	7	17	20	14	8	0.748	-0.115	4.15	0.013	0.01	0	44.7	42.1	61.5	138	131	0	34	33
2015	7	17	20	24	8	0.755	-0.072	4.15	0.013	0.01	0	45.2	42.1	59.8	139	131	0	34	33
2015	7	17	20	34	8	0.748	-0.079	4.147	0.01	0.007	0	45.6	42.1	63.2	139	131	0	33	33
2015	7	17	20	44	8	0.745	-0.108	4.147	0.01	0.007	0	44.7	42.6	61.1	138	131	0	34	32
2015	7	17	20	54	8	0.696	-0.089	4.147	0.013	0.01	0	45.2	42.1	65.8	139	131	0	34	33
2015	7	17	21	4	8	0.728	-0.075	4.144	0.01	0.007	0	45.2	42.1	57.2	140	131	0	35	33
2015	7	17	21	14	8	0.722	-0.069	4.147	0.01	0.007	0	45.2	42.1	63.6	139	131	0	34	33
2015	7	17	21	24	8	0.761	-0.082	4.147	0.01	0.007	0	44.7	42.1	64.1	139	131	0	35	33
2015	7	17	21	34	8	0.712	-0.036	4.144	0.013	0.01	0	45.2	42.1	61.5	139	131	0	34	33
2015	7	17	21	44	8	0.715	-0.089	4.144	0.01	0.007	0	44.3	41.7	65.8	138	130	0	35	33
2015	7	17	21	54	8	0.712	-0.105	4.14	0.01	0.007	0	44.7	41.7	65.8	138	130	0	34	33
2015	7	17	22	4	8	0.741	-0.082	4.144	0.01	0.007	0	45.2	41.7	62.8	138	130	0	33	33
2015	7	17	22	14	8	0.735	-0.075	4.14	0.013	0.01	0	45.2	42.1	66.2	138	131	0	33	33
2015	7	17	22	24	8	0.719	-0.069	4.14	0.01	0.007	0	45.2	41.7	67.1	138	130	0	33	33
2015	7	17	22	34	8	0.732	-0.056	4.14	0.01	0.007	0	44.7	41.7	66.2	138	130	0	34	33
2015	7	17	22	44	8	0.771	-0.082	4.14	0.01	0.007	0	44.3	41.7	66.7	137	130	0	34	33
2015	7	17	22	54	8	0.715	-0.089	4.14	0.01	0.007	0	45.2	41.7	59.8	138	130	0	33	33
2015	7	17	23	4	8	0.686	-0.108	4.14	0.016	0.013	0	45.2	42.1	58	138	130	0	33	32
2015	7	17	23	14	8	0.722	-0.095	4.14	0.013	0.01	0	44.3	41.7	58	137	130	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	17	23	24	8	0.751	-0.102	4.144	0.016	0.013	0	43.4	40.9	55	136	128	0	35	33
2015	7	17	23	34	8	0.728	-0.036	4.14	0.01	0.007	0	45.2	41.7	59.8	139	130	0	34	33
2015	7	17	23	44	8	0.738	-0.102	4.137	0.013	0.01	0	44.3	41.3	59.3	137	129	0	34	33
2015	7	17	23	54	8	0.712	-0.098	4.14	0.01	0.007	0	43.9	41.3	66.2	137	129	0	35	33
2015	7	18	0	4	8	0.728	-0.079	4.137	0.01	0.007	0	45.2	42.1	65.8	139	131	0	34	33
2015	7	18	0	14	8	0.745	-0.125	4.137	0.01	0.007	0	44.7	41.7	67.5	137	129	0	33	32
2015	7	18	0	24	8	0.725	-0.043	4.137	0.013	0.01	0	44.3	41.3	66.2	137	129	0	34	33
2015	7	18	0	34	8	0.748	-0.069	4.137	0.01	0.007	0	45.2	41.7	66.2	138	130	0	33	33
2015	7	18	0	44	8	0.738	-0.079	4.137	0.013	0.01	0	44.3	41.7	59.8	138	130	0	35	33
2015	7	18	0	54	8	0.745	-0.102	4.14	0.013	0.01	0	44.7	41.3	52.5	137	129	0	33	33
2015	7	18	1	4	8	0.735	-0.082	4.14	0.016	0.013	0	44.3	41.7	52.5	137	130	0	34	33
2015	7	18	1	14	8	0.696	-0.089	4.14	0.016	0.013	0	44.3	41.7	50.7	137	130	0	34	33
2015	7	18	1	24	8	0.728	-0.079	4.144	0.01	0.007	0	44.3	41.3	49.5	137	129	0	34	33
2015	7	18	1	34	8	0.735	-0.066	4.144	0.01	0.007	0	44.7	41.7	50.7	138	130	0	34	33
2015	7	18	1	44	8	0.715	-0.095	4.14	0.013	0.01	0	44.7	41.3	50.3	138	130	0	34	34
2015	7	18	1	54	8	0.745	-0.131	4.14	0.01	0.007	0	43.4	40.9	52	136	128	0	35	33
2015	7	18	2	4	8	0.751	-0.082	4.134	0.016	0.013	0	44.7	41.7	67.5	138	130	0	34	33
2015	7	18	2	14	8	0.755	-0.105	4.137	0.01	0.007	0	44.7	41.7	67.1	138	130	0	34	33
2015	7	18	2	24	8	0.728	-0.043	4.137	0.01	0.007	0	44.3	41.7	67.1	137	130	0	34	33
2015	7	18	2	34	8	0.745	-0.089	4.137	0.013	0.01	0	44.3	41.3	67.5	137	129	0	34	33
2015	7	18	2	44	8	0.758	-0.092	4.134	0.01	0.007	0	43.9	41.3	67.1	137	129	0	35	33
2015	7	18	2	54	8	0.764	-0.072	4.134	0.01	0.007	0	44.3	41.3	65.8	137	129	0	34	33
2015	7	18	3	4	8	0.712	-0.069	4.134	0.01	0.007	0	44.7	41.7	59.3	138	130	0	34	33
2015	7	18	3	14	8	0.728	-0.082	4.134	0.013	0.01	0	44.3	41.7	67.9	137	130	0	34	33
2015	7	18	3	24	8	0.719	-0.085	4.134	0.01	0.007	0	43.9	41.3	67.1	136	129	0	34	33
2015	7	18	3	34	8	0.728	-0.059	4.134	0.013	0.01	0	44.3	41.7	67.9	137	130	0	34	33
2015	7	18	3	44	8	0.768	-0.082	4.134	0.013	0.01	0	43.9	40.9	67.9	136	129	0	34	34
2015	7	18	3	54	8	0.702	-0.052	4.134	0.016	0.013	0	44.3	41.7	67.5	137	130	0	34	33
2015	7	18	4	4	8	0.715	-0.079	4.134	0.01	0.007	0	44.3	41.3	67.5	137	129	0	34	33
2015	7	18	4	14	8	0.748	-0.095	4.134	0.01	0.007	0	44.3	41.7	67.5	138	130	0	35	33
2015	7	18	4	24	8	0.738	-0.089	4.131	0.01	0.007	0	44.7	40.9	67.1	138	129	0	34	34
2015	7	18	4	34	8	0.725	-0.056	4.131	0.01	0.007	0	44.3	41.3	67.1	138	129	0	35	33
2015	7	18	4	44	8	0.741	-0.085	4.134	0.01	0.007	0	44.7	40.9	67.5	138	129	0	34	34
2015	7	18	4	54	8	0.728	-0.075	4.131	0.01	0.007	0	44.7	42.1	67.5	139	131	0	35	33
2015	7	18	5	4	8	0.719	-0.075	4.131	0.01	0.007	0	44.3	40.9	67.9	137	129	0	34	34
2015	7	18	5	14	8	0.709	-0.056	4.131	0.01	0.007	0	44.7	41.7	67.9	138	130	0	34	33
2015	7	18	5	24	8	0.748	-0.056	4.131	0.01	0.007	0	44.7	41.7	67.9	138	129	0	34	32
2015	7	18	5	34	8	0.771	-0.105	4.131	0.013	0.01	0	44.3	41.3	68.8	137	129	0	34	33
2015	7	18	5	44	8	0.732	-0.066	4.131	0.016	0.013	0	44.7	41.7	68.4	137	129	0	33	32
2015	7	18	5	54	8	0.764	-0.082	4.131	0.01	0.007	0	43.9	41.3	68.4	137	129	0	35	33
2015	7	18	6	4	8	0.732	-0.066	4.127	0.01	0.007	0	43.9	40.9	68.4	136	128	0	34	33
2015	7	18	6	14	8	0.719	-0.082	4.127	0.016	0.016	0	43.4	40.9	68.4	136	128	0	35	33
2015	7	18	6	24	8	0.689	-0.066	4.127	0.013	0.01	0	43.9	40.9	68.8	136	128	0	34	33
2015	7	18	6	34	8	0.722	-0.056	4.127	0.01	0.007	0	43.4	40.4	68.4	135	127	0	34	33
2015	7	18	6	44	8	0.751	-0.085	4.127	0.01	0.007	0	43.4	40	68.4	135	127	0	34	34
2015	7	18	6	54	8	0.741	-0.089	4.127	0.01	0.007	0	43.4	40	69.2	135	127	0	34	34
2015	7	18	7	4	8	0.725	-0.098	4.127	0.016	0.016	0	43.4	40	68.8	135	126	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	18	7	14	8	0.728	-0.036	4.127	0.01	0.007	0	43.9	40.4	68.4	136	128	0	34	34
2015	7	18	7	24	8	0.748	-0.089	4.127	0.01	0.007	0	43.4	40	68.8	135	127	0	34	34
2015	7	18	7	34	8	0.748	-0.121	4.127	0.01	0.007	0	43.4	40.4	69.2	135	127	0	34	33
2015	7	18	7	44	8	0.758	-0.079	4.127	0.01	0.007	0	43.4	40.4	69.2	135	127	0	34	33
2015	7	18	7	54	8	0.722	-0.075	4.127	0.013	0.01	0	43.9	40.9	69.2	136	128	0	34	33
2015	7	18	8	4	8	0.722	-0.085	4.124	0.01	0.007	0	43.9	40.4	69.7	136	128	0	34	34
2015	7	18	8	14	8	0.741	-0.095	4.124	0.013	0.01	0	44.3	41.3	70.1	137	129	0	34	33
2015	7	18	8	24	8	0.738	-0.095	4.124	0.01	0.007	0	44.3	41.3	70.5	137	129	0	34	33
2015	7	18	8	34	8	0.735	-0.092	4.124	0.01	0.007	0	43.9	41.3	70.1	136	129	0	34	33
2015	7	18	8	44	8	0.715	-0.089	4.124	0.013	0.01	0	43.4	40.9	69.2	136	128	0	35	33
2015	7	18	8	54	8	0.755	-0.121	4.124	0.01	0.007	0	43.4	40.9	64.1	135	128	0	34	33
2015	7	18	9	4	8	0.745	-0.135	4.121	0.013	0.01	0	43	40	67.1	134	127	0	34	34
2015	7	18	9	14	8	0.751	-0.131	4.121	0.013	0.01	0	43.4	40	63.2	135	127	0	34	34
2015	7	18	9	24	8	0.764	-0.148	4.121	0.01	0.007	0	43.4	40	66.7	135	127	0	34	34
2015	7	18	9	34	8	0.735	-0.135	4.121	0.01	0.007	0	43	40.9	69.7	135	128	0	35	33
2015	7	18	9	44	8	0.735	-0.151	4.121	0.016	0.013	0	43.4	40.9	69.7	135	128	0	34	33
2015	7	18	9	54	8	0.732	-0.098	4.121	0.01	0.007	0	43.4	40	71	135	127	0	34	34
2015	7	18	10	4	8	0.735	-0.098	4.121	0.016	0.013	0	43.4	40.4	64.9	135	127	0	34	33
2015	7	18	10	14	8	0.738	-0.105	4.117	0.01	0.007	0	43.4	40.4	61.9	135	128	0	34	34
2015	7	18	10	24	8	0.732	-0.115	4.117	0.01	0.007	0	43.4	40.9	60.2	135	128	0	34	33
2015	7	18	10	34	8	0.732	-0.138	4.117	0.013	0.01	0	43	40.4	58	135	127	0	35	33
2015	7	18	10	44	8	0.728	-0.098	4.117	0.01	0.007	0	43.4	41.3	55	136	129	0	35	33
2015	7	18	10	54	8	0.728	-0.085	4.117	0.01	0.007	0	43.4	41.3	54.2	136	129	0	35	33
2015	7	18	11	4	8	0.738	-0.141	4.114	0.016	0.013	0	43.4	40.4	55.9	135	127	0	34	33
2015	7	18	11	14	8	0.709	-0.102	4.114	0.01	0.007	0	43	40.9	54.2	135	128	0	35	33
2015	7	18	11	24	8	0.709	-0.108	4.111	0.01	0.007	0	43.9	40.9	49.5	136	128	0	34	33
2015	7	18	11	34	8	0.709	-0.144	4.108	0.01	0.007	0	43.4	40.4	50.7	135	127	0	34	33
2015	7	18	11	44	8	0.725	-0.135	4.111	0.013	0.01	0	43.9	40.9	57.6	136	128	0	34	33
2015	7	18	11	54	8	0.712	-0.157	4.108	0.01	0.007	0	43.9	41.3	62.4	136	129	0	34	33
2015	7	18	12	4	8	0.732	-0.161	4.108	0.01	0.007	0	43.4	40.4	50.3	135	127	0	34	33
2015	7	18	12	14	8	0.692	-0.154	4.104	0.013	0.01	0	43.9	40.9	53.3	136	128	0	34	33
2015	7	18	12	24	8	0.755	-0.125	4.098	0.01	0.007	0	43.9	41.7	63.6	137	130	0	35	33
2015	7	18	12	34	8	0.712	-0.151	4.101	0.01	0.007	0	43	40.4	52.5	135	127	0	35	33
2015	7	18	12	44	8	0.715	-0.102	4.101	0.01	0.007	0	43.9	40.9	54.6	136	128	0	34	33
2015	7	18	12	54	8	0.741	-0.115	4.098	0.01	0.007	0	43.9	40.9	52	136	128	0	34	33
2015	7	18	13	4	8	0.682	-0.161	4.094	0.01	0.007	0	43.9	40.9	54.2	136	128	0	34	33
2015	7	18	13	14	8	0.702	-0.102	4.098	0.01	0.007	0	43.9	40.9	48.6	137	129	0	35	34
2015	7	18	13	24	8	0.732	-0.138	4.094	0.016	0.013	0	44.3	41.3	48.6	137	129	0	34	33
2015	7	18	13	34	8	0.712	-0.157	4.091	0.01	0.007	0	44.3	41.7	49	137	130	0	34	33
2015	7	18	13	44	8	0.709	-0.079	4.094	0.01	0.007	0	45.2	42.1	49.5	139	131	0	34	33
2015	7	18	13	54	8	0.699	-0.082	4.091	0.01	0.007	0	50.7	48.6	46	152	145	0	34	32
2015	7	18	14	4	8	0.709	-0.108	4.088	0.013	0.01	0	52	49.5	43.4	156	149	0	35	34
2015	7	18	14	14	8	0.738	-0.052	4.085	0.013	0.01	0	51.2	48.6	44.7	153	146	0	34	33
2015	7	18	14	24	8	0.709	-0.082	4.088	0.01	0.007	0	50.3	47.3	47.3	151	143	0	34	33
2015	7	18	14	34	8	0.692	-0.072	4.091	0.013	0.01	0	50.3	46.9	45.6	151	143	0	34	34
2015	7	18	14	44	8	0.699	-0.079	4.088	0.013	0.01	0	49.5	46.4	47.7	149	141	0	34	33
2015	7	18	14	54	8	0.692	-0.105	4.085	0.01	0.007	0	49	46.4	46	148	141	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	18	15	4	8	0.692	-0.082	4.091	0.01	0.007	0	48.6	45.6	47.7	147	139	0	34	33
2015	7	18	15	14	8	0.692	-0.125	4.081	0.01	0.007	0	47.3	45.2	48.2	145	138	0	35	33
2015	7	18	15	24	8	0.719	-0.118	4.085	0.013	0.01	0	47.3	44.3	49.5	144	136	0	34	33
2015	7	18	15	34	8	0.686	-0.098	4.081	0.016	0.013	0	47.3	44.3	46.9	144	136	0	34	33
2015	7	18	15	44	8	0.692	-0.108	4.081	0.013	0.01	0	46.4	43.9	48.6	143	136	0	35	34
2015	7	18	15	54	8	0.719	-0.066	4.081	0.01	0.007	0	46.9	44.3	49	143	136	0	34	33
2015	7	18	16	4	8	0.699	-0.105	4.081	0.01	0.007	0	46.4	44.3	49.5	142	135	0	34	32
2015	7	18	16	14	8	0.705	-0.102	4.075	0.01	0.007	0	46.9	43.9	49	143	135	0	34	33
2015	7	18	16	24	8	0.692	-0.092	4.078	0.01	0.007	0	47.3	44.3	49	144	136	0	34	33
2015	7	18	16	34	8	0.741	-0.062	4.075	0.01	0.007	0	47.3	44.3	49.9	144	136	0	34	33
2015	7	18	16	44	8	0.679	-0.075	4.078	0.01	0.007	0	46.4	44.3	48.6	143	136	0	35	33
2015	7	18	16	54	8	0.725	-0.052	4.075	0.01	0.007	0	46.4	43.9	49	143	135	0	35	33
2015	7	18	17	4	8	0.722	-0.072	4.075	0.01	0.007	0	46.4	43.9	49.9	143	135	0	35	33
2015	7	18	17	14	8	0.741	-0.069	4.075	0.01	0.007	0	46	43.9	48.6	142	134	0	35	32
2015	7	18	17	24	8	0.748	-0.098	4.068	0.01	0.007	0	46	42.6	50.3	141	133	0	34	34
2015	7	18	17	34	8	0.712	-0.092	4.078	0.013	0.01	0	46.4	43.4	48.2	142	134	0	34	33
2015	7	18	17	44	8	0.715	-0.072	4.072	0.01	0.007	0	45.6	43	47.7	141	133	0	35	33
2015	7	18	17	54	8	0.738	-0.115	4.072	0.01	0.007	0	45.6	42.6	49	140	132	0	34	33
2015	7	18	18	4	8	0.722	-0.072	4.068	0.01	0.007	0	45.2	42.1	48.2	139	132	0	34	34
2015	7	18	18	14	8	0.712	-0.066	4.068	0.01	0.007	0	44.7	41.7	49	138	131	0	34	34
2015	7	18	18	24	8	0.722	-0.072	4.068	0.01	0.007	0	45.2	41.7	51.2	139	131	0	34	34
2015	7	18	18	34	8	0.738	-0.072	4.068	0.016	0.013	0	45.2	42.1	52.9	139	131	0	34	33
2015	7	18	18	44	8	0.725	-0.056	4.068	0.01	0.007	0	44.7	42.1	52	139	131	0	35	33
2015	7	18	18	54	8	0.692	-0.115	4.065	0.01	0.007	0	44.3	42.1	49.5	138	131	0	35	33
2015	7	18	19	4	8	0.709	-0.082	4.062	0.013	0.01	0	46	43.4	48.2	141	133	0	34	32
2015	7	18	19	14	8	0.709	-0.095	4.065	0.01	0.007	0	46	43.4	48.6	141	133	0	34	32
2015	7	18	19	24	8	0.735	-0.082	4.065	0.01	0.007	0	45.2	43	50.3	140	133	0	35	33
2015	7	18	19	34	8	0.748	-0.089	4.068	0.01	0.007	0	46.4	43.4	47.7	142	134	0	34	33
2015	7	18	19	44	8	0.722	-0.082	4.065	0.01	0.007	0	45.2	42.6	49.5	140	132	0	35	33
2015	7	18	19	54	8	0.719	-0.092	4.065	0.013	0.01	0	45.6	42.6	48.6	140	132	0	34	33
2015	7	18	20	4	8	0.709	-0.095	4.062	0.01	0.007	0	46	42.6	47.7	141	133	0	34	34
2015	7	18	20	14	8	0.725	-0.092	4.062	0.01	0.007	0	46	43	49.5	141	133	0	34	33
2015	7	18	20	24	8	0.696	-0.085	4.062	0.016	0.013	0	46	42.6	50.7	141	132	0	34	33
2015	7	18	20	34	8	0.715	-0.095	4.058	0.01	0.007	0	46.4	43.4	51.6	142	134	0	34	33
2015	7	18	20	44	8	0.709	-0.062	4.058	0.01	0.007	0	46.4	43.9	51.6	142	134	0	34	32
2015	7	18	20	54	8	0.709	-0.092	4.062	0.01	0.007	0	46.9	43.4	49.9	143	134	0	34	33
2015	7	18	21	4	8	0.705	-0.062	4.058	0.013	0.01	0	46	42.6	51.2	142	133	0	35	34
2015	7	18	21	14	8	0.696	-0.085	4.062	0.013	0.01	0	46.4	43	49	142	133	0	34	33
2015	7	18	21	24	8	0.722	-0.056	4.058	0.01	0.007	0	46	43	50.3	141	133	0	34	33
2015	7	18	21	34	8	0.689	-0.062	4.058	0.013	0.01	0	46	42.1	50.7	141	132	0	34	34
2015	7	18	21	44	8	0.696	-0.115	4.058	0.01	0.007	0	45.2	41.7	52.5	139	131	0	34	34
2015	7	18	21	54	8	0.725	-0.115	4.055	0.01	0.007	0	44.7	41.7	54.6	138	130	0	34	33
2015	7	18	22	4	8	0.725	-0.102	4.052	0.01	0.007	0	46	42.6	58.9	140	132	0	33	33
2015	7	18	22	14	8	0.705	-0.118	4.052	0.01	0.007	0	45.2	42.1	67.1	139	131	0	34	33
2015	7	18	22	24	8	0.705	-0.102	4.052	0.013	0.01	0	45.2	42.6	66.7	140	132	0	35	33
2015	7	18	22	34	8	0.719	-0.085	4.052	0.01	0.007	0	45.2	42.1	65.8	139	131	0	34	33
2015	7	18	22	44	8	0.728	-0.075	4.052	0.013	0.01	0	45.2	42.1	68.4	139	131	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	18	22	54	8	0.705	-0.082	4.052	0.01	0.007	0	45.6	42.6	68.8	140	132	0	34	33
2015	7	18	23	4	8	0.712	-0.075	4.052	0.01	0.007	0	44.7	42.1	68.4	139	131	0	35	33
2015	7	18	23	14	8	0.702	-0.082	4.052	0.013	0.01	0	45.6	42.6	67.9	140	132	0	34	33
2015	7	18	23	24	8	0.755	-0.082	4.052	0.013	0.01	0	45.2	42.1	68.8	139	131	0	34	33
2015	7	18	23	34	8	0.692	-0.092	4.052	0.01	0.007	0	46	42.6	68.4	140	132	0	33	33
2015	7	18	23	44	8	0.725	-0.066	4.052	0.01	0.007	0	45.6	42.1	68.8	140	131	0	34	33
2015	7	18	23	54	8	0.732	-0.095	4.052	0.016	0.013	0	45.2	41.7	69.2	139	131	0	34	34
2015	7	19	0	4	8	0.712	-0.082	4.052	0.013	0.01	0	45.6	42.6	68.4	140	132	0	34	33
2015	7	19	0	14	8	0.682	-0.102	4.052	0.01	0.007	0	44.7	42.1	68.8	139	131	0	35	33
2015	7	19	0	24	8	0.719	-0.092	4.049	0.01	0.007	0	45.6	42.1	68.4	140	131	0	34	33
2015	7	19	0	34	8	0.719	-0.059	4.049	0.01	0.007	0	45.6	42.6	68.8	140	132	0	34	33
2015	7	19	0	44	8	0.709	-0.066	4.049	0.01	0.007	0	45.6	42.6	68.8	140	132	0	34	33
2015	7	19	0	54	8	0.705	-0.089	4.049	0.013	0.01	0	44.7	42.1	69.2	139	131	0	35	33
2015	7	19	1	4	8	0.692	-0.056	4.049	0.01	0.007	0	45.6	42.6	66.7	140	132	0	34	33
2015	7	19	1	14	8	0.741	-0.075	4.049	0.013	0.01	0	44.7	41.7	68.4	139	131	0	35	34
2015	7	19	1	24	8	0.722	-0.098	4.049	0.013	0.01	0	45.2	41.7	68.4	139	131	0	34	34
2015	7	19	1	34	8	0.705	-0.089	4.049	0.01	0.007	0	45.6	42.1	69.2	140	131	0	34	33
2015	7	19	1	44	8	0.722	-0.079	4.049	0.013	0.01	0	45.6	41.7	69.7	140	131	0	34	34
2015	7	19	1	54	8	0.673	-0.079	4.049	0.01	0.007	0	45.2	42.1	68.4	139	131	0	34	33
2015	7	19	2	4	8	0.709	-0.121	4.049	0.01	0.007	0	45.2	42.1	69.2	139	131	0	34	33
2015	7	19	2	14	8	0.732	-0.095	4.049	0.013	0.01	0	44.7	42.1	69.2	139	131	0	35	33
2015	7	19	2	24	8	0.722	-0.079	4.049	0.013	0.01	0	44.3	41.7	69.2	138	130	0	35	33
2015	7	19	2	34	8	0.712	-0.092	4.049	0.013	0.01	0	44.7	41.7	68.8	138	130	0	34	33
2015	7	19	2	44	8	0.689	-0.115	4.049	0.01	0.007	0	45.6	41.3	68.8	139	130	0	33	34
2015	7	19	2	54	8	0.709	-0.098	4.049	0.013	0.01	0	45.2	42.1	68.4	139	131	0	34	33
2015	7	19	3	4	8	0.676	-0.056	4.049	0.01	0.007	0	45.2	42.1	67.1	139	131	0	34	33
2015	7	19	3	14	8	0.689	-0.092	4.049	0.01	0.007	0	43.9	41.7	69.2	137	130	0	35	33
2015	7	19	3	24	8	0.699	-0.112	4.045	0.013	0.01	0	44.7	41.7	68.8	139	130	0	35	33
2015	7	19	3	34	8	0.722	-0.112	4.045	0.01	0.007	0	45.2	41.7	68.8	139	130	0	34	33
2015	7	19	3	44	8	0.702	-0.098	4.045	0.013	0.01	0	44.7	41.3	69.2	138	129	0	34	33
2015	7	19	3	54	8	0.705	-0.098	4.045	0.01	0.007	0	45.2	40.9	69.2	139	129	0	34	34
2015	7	19	4	4	8	0.732	-0.115	4.045	0.016	0.013	0	45.2	41.7	68.8	139	130	0	34	33
2015	7	19	4	14	8	0.712	-0.066	4.045	0.013	0.01	0	45.6	42.1	69.7	140	131	0	34	33
2015	7	19	4	24	8	0.725	-0.095	4.045	0.01	0.007	0	45.6	42.6	69.7	140	131	0	34	32
2015	7	19	4	34	8	0.689	-0.069	4.045	0.01	0.007	0	45.2	41.7	69.2	139	130	0	34	33
2015	7	19	4	44	8	0.712	-0.092	4.045	0.016	0.013	0	44.7	41.7	69.2	139	130	0	35	33
2015	7	19	4	54	8	0.715	-0.066	4.045	0.01	0.007	0	45.2	42.1	68.4	139	131	0	34	33
2015	7	19	5	4	8	0.712	-0.082	4.045	0.01	0.007	0	45.2	42.6	69.2	139	132	0	34	33
2015	7	19	5	14	8	0.702	-0.108	4.045	0.013	0.01	0	45.6	42.6	68.8	140	132	0	34	33
2015	7	19	5	24	8	0.712	-0.115	4.045	0.016	0.013	0	45.6	42.6	68.8	140	132	0	34	33
2015	7	19	5	34	8	0.702	-0.092	4.042	0.01	0.007	0	44.7	42.1	68.8	138	131	0	34	33
2015	7	19	5	44	8	0.682	-0.112	4.042	0.016	0.013	0	45.2	42.1	68.4	140	131	0	35	33
2015	7	19	5	54	8	0.692	-0.089	4.042	0.01	0.007	0	44.7	42.1	69.2	139	130	0	35	32
2015	7	19	6	4	8	0.719	-0.085	4.042	0.016	0.013	0	45.6	42.6	69.2	140	132	0	34	33
2015	7	19	6	14	8	0.689	-0.108	4.042	0.01	0.007	0	45.2	42.1	68.4	139	131	0	34	33
2015	7	19	6	24	8	0.689	-0.082	4.042	0.01	0.007	0	44.7	41.7	69.2	139	130	0	35	33
2015	7	19	6	34	8	0.715	-0.072	4.042	0.013	0.01	0	44.7	41.7	70.1	138	130	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	19	6	44	8	0.699	-0.089	4.042	0.013	0.01	0	44.7	40.9	69.7	138	129	0	34	34
2015	7	19	6	54	8	0.702	-0.095	4.042	0.01	0.007	0	44.7	41.3	67.9	138	129	0	34	33
2015	7	19	7	4	8	0.735	-0.112	4.042	0.01	0.007	0	44.3	41.3	69.7	138	129	0	35	33
2015	7	19	7	14	8	0.735	-0.108	4.042	0.013	0.01	0	44.3	40.9	69.7	138	129	0	35	34
2015	7	19	7	24	8	0.699	-0.052	4.042	0.01	0.007	0	44.7	41.3	69.2	138	129	0	34	33
2015	7	19	7	34	8	0.686	-0.082	4.042	0.016	0.013	0	44.3	41.3	69.2	138	130	0	35	34
2015	7	19	7	44	8	0.702	-0.098	4.042	0.01	0.007	0	44.3	41.7	65.4	138	130	0	35	33
2015	7	19	7	54	8	0.702	-0.085	4.042	0.01	0.007	0	44.3	41.3	67.9	138	130	0	35	34
2015	7	19	8	4	8	0.686	-0.098	4.042	0.013	0.01	0	44.3	41.7	67.9	137	130	0	34	33
2015	7	19	8	14	8	0.709	-0.098	4.039	0.01	0.007	0	44.7	41.7	71	139	130	0	35	33
2015	7	19	8	24	8	0.738	-0.118	4.039	0.01	0.007	0	44.3	40.9	63.2	137	128	0	34	33
2015	7	19	8	34	8	0.689	-0.115	4.039	0.01	0.007	0	44.3	41.3	70.5	137	129	0	34	33
2015	7	19	8	44	8	0.696	-0.069	4.039	0.01	0.007	0	44.7	42.1	67.9	139	131	0	35	33
2015	7	19	8	54	8	0.725	-0.105	4.039	0.013	0.01	0	44.3	41.3	67.9	137	129	0	34	33
2015	7	19	9	4	8	0.722	-0.115	4.039	0.013	0.01	0	44.3	41.7	66.2	138	130	0	35	33
2015	7	19	9	14	8	0.709	-0.095	4.039	0.016	0.013	0	44.7	42.1	64.1	139	131	0	35	33
2015	7	19	9	24	8	0.719	-0.138	4.039	0.01	0.007	0	44.3	40.9	70.1	137	129	0	34	34
2015	7	19	9	34	8	0.709	-0.154	4.039	0.01	0.007	0	43.9	41.3	69.2	137	129	0	35	33
2015	7	19	9	44	8	0.699	-0.112	4.039	0.01	0.007	0	45.2	42.1	64.1	139	131	0	34	33
2015	7	19	9	54	8	0.715	-0.144	4.039	0.01	0.007	0	44.3	41.7	55	138	130	0	35	33
2015	7	19	10	4	8	0.709	-0.089	4.039	0.01	0.007	0	43.9	41.3	67.5	137	129	0	35	33
2015	7	19	10	14	8	0.728	-0.135	4.039	0.01	0.007	0	44.3	41.7	70.5	137	130	0	34	33
2015	7	19	10	24	8	0.732	-0.121	4.039	0.01	0.007	0	44.3	41.7	56.3	138	130	0	35	33
2015	7	19	10	34	8	0.699	-0.089	4.035	0.01	0.007	0	44.7	42.1	64.1	139	131	0	35	33
2015	7	19	10	44	8	0.699	-0.128	4.035	0.01	0.007	0	44.7	42.1	70.1	139	131	0	35	33
2015	7	19	10	54	8	0.735	-0.085	4.035	0.013	0.01	0	45.2	42.1	60.6	139	131	0	34	33
2015	7	19	11	4	8	0.705	-0.095	4.035	0.01	0.007	0	45.2	42.1	64.5	139	131	0	34	33
2015	7	19	11	14	8	0.722	-0.039	4.035	0.01	0.007	0	45.6	42.6	68.8	140	132	0	34	33
2015	7	19	11	24	8	0.722	-0.069	4.032	0.01	0.007	0	45.2	42.1	54.6	139	131	0	34	33
2015	7	19	11	34	8	0.712	-0.125	4.032	0.013	0.01	0	43.9	40.9	64.5	136	128	0	34	33
2015	7	19	11	44	8	0.705	-0.128	4.032	0.01	0.007	0	44.7	41.7	61.1	138	130	0	34	33
2015	7	19	11	54	8	0.719	-0.135	4.032	0.01	0.007	0	43.9	40.9	64.5	136	128	0	34	33
2015	7	19	12	4	8	0.719	-0.125	4.029	0.01	0.007	0	44.3	41.3	63.6	137	129	0	34	33
2015	7	19	12	14	8	0.702	-0.121	4.029	0.01	0.007	0	44.3	41.7	66.2	137	130	0	34	33
2015	7	19	12	24	8	0.719	-0.131	4.029	0.01	0.007	0	44.3	41.7	61.5	138	130	0	35	33
2015	7	19	12	34	8	0.715	-0.112	4.026	0.01	0.007	0	44.3	41.7	65.8	138	130	0	35	33
2015	7	19	12	44	8	0.732	-0.128	4.022	0.013	0.01	0	44.7	41.7	66.2	138	130	0	34	33
2015	7	19	12	54	8	0.722	-0.125	4.019	0.01	0.007	0	44.3	41.7	67.1	138	130	0	35	33
2015	7	19	13	4	8	0.722	-0.102	4.019	0.01	0.007	0	45.6	42.6	64.1	140	132	0	34	33
2015	7	19	13	14	8	0.692	-0.161	4.019	0.016	0.013	0	44.3	41.7	51.6	137	130	0	34	33
2015	7	19	13	24	8	0.715	-0.098	4.016	0.01	0.007	0	45.2	42.1	63.2	139	131	0	34	33
2015	7	19	13	34	8	0.719	-0.141	4.016	0.01	0.007	0	43.4	41.3	52.9	136	129	0	35	33
2015	7	19	13	44	8	0.682	-0.135	4.016	0.013	0.01	0	43.9	40.9	52.9	136	128	0	34	33
2015	7	19	13	54	8	0.712	-0.174	4.012	0.01	0.007	0	44.3	41.3	62.4	137	129	0	34	33
2015	7	19	14	4	8	0.715	-0.144	4.012	0.013	0.01	0	43.9	41.3	64.9	137	129	0	35	33
2015	7	19	14	14	8	0.722	-0.151	4.012	0.01	0.007	0	44.3	41.3	65.8	138	130	0	35	34
2015	7	19	14	24	8	0.709	-0.138	4.012	0.01	0.007	0	43.9	41.3	67.5	137	130	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	19	14	34	8	0.673	-0.118	4.012	0.013	0.01	0	44.3	40.9	69.7	137	129	0	34	34
2015	7	19	14	44	8	0.705	-0.115	4.009	0.01	0.007	0	45.2	42.1	67.1	139	131	0	34	33
2015	7	19	14	54	8	0.699	-0.095	4.009	0.016	0.013	0	45.2	42.1	69.2	140	131	0	35	33
2015	7	19	15	4	8	0.709	-0.095	4.009	0.013	0.01	0	45.6	43	67.9	140	133	0	34	33
2015	7	19	15	14	8	0.679	-0.085	4.009	0.013	0.01	0	45.6	42.6	67.9	140	132	0	34	33
2015	7	19	15	24	8	0.682	-0.095	4.009	0.013	0.01	0	45.2	42.1	66.2	139	132	0	34	34
2015	7	19	15	34	8	0.735	-0.059	4.009	0.01	0.007	0	45.6	43	67.5	140	133	0	34	33
2015	7	19	15	44	8	0.712	-0.075	4.009	0.013	0.01	0	45.6	42.6	69.7	140	132	0	34	33
2015	7	19	15	54	8	0.741	-0.082	4.006	0.013	0.01	0	44.7	42.6	58	139	131	0	35	32
2015	7	19	16	4	8	0.692	-0.118	4.006	0.01	0.007	0	45.2	42.1	68.8	139	131	0	34	33
2015	7	19	16	14	8	0.705	-0.141	4.006	0.01	0.007	0	44.7	41.3	68.8	137	129	0	33	33
2015	7	19	16	24	8	0.709	-0.092	4.006	0.01	0.007	0	44.3	41.3	59.3	137	129	0	34	33
2015	7	19	16	34	8	0.719	-0.141	4.006	0.013	0.01	0	44.3	40.9	67.1	137	129	0	34	34
2015	7	19	16	44	8	0.722	-0.098	4.006	0.013	0.01	0	45.6	42.1	43.4	139	131	0	33	33
2015	7	19	16	54	8	0.692	-0.135	4.003	0.01	0.007	0	46.9	42.6	43.9	143	132	0	34	33
2015	7	19	17	4	8	0.715	-0.112	4.003	0.013	0.01	0	47.3	43	46.4	144	133	0	34	33
2015	7	19	17	14	8	0.702	-0.144	3.99	0.013	0.01	0	47.3	43.4	44.7	144	134	0	34	33
2015	7	19	17	24	8	0.682	-0.089	4.006	0.01	0.007	0	46.4	43.4	49.5	142	133	0	34	32
2015	7	19	17	34	8	0.689	-0.148	4.003	0.013	0.01	0	47.7	43.4	47.7	145	135	0	34	34
2015	7	19	17	44	8	0.705	-0.121	4.006	0.016	0.013	0	46	43	46.4	141	133	0	34	33
2015	7	19	17	54	8	0.692	-0.102	4.006	0.01	0.007	0	45.6	43	49.9	140	133	0	34	33
2015	7	19	18	4	8	0.712	-0.125	4.003	0.01	0.007	0	45.6	43	49.5	140	133	0	34	33
2015	7	19	18	14	8	0.715	-0.112	4.003	0.01	0.007	0	45.2	41.7	49.9	139	131	0	34	34
2015	7	19	18	24	8	0.699	-0.112	4.003	0.01	0.007	0	44.7	41.7	49	138	130	0	34	33
2015	7	19	18	34	8	0.702	-0.098	3.999	0.01	0.007	0	44.3	41.3	49	138	130	0	35	34
2015	7	19	18	44	8	0.699	-0.082	4.003	0.013	0.01	0	44.7	41.7	51.6	138	130	0	34	33
2015	7	19	18	54	8	0.712	-0.092	4.003	0.013	0.01	0	44.7	42.1	50.7	139	131	0	35	33
2015	7	19	19	4	8	0.709	-0.102	4.003	0.01	0.007	0	45.2	42.1	58.5	139	131	0	34	33
2015	7	19	19	14	8	0.692	-0.079	4.003	0.01	0.007	0	45.6	42.1	57.2	140	131	0	34	33
2015	7	19	19	24	8	0.689	-0.095	4.003	0.01	0.007	0	46.4	43.4	54.2	142	134	0	34	33
2015	7	19	19	34	8	0.686	-0.085	4.003	0.01	0.007	0	46.9	43.9	58	143	135	0	34	33
2015	7	19	19	44	8	0.659	-0.092	4.003	0.01	0.007	0	46.4	43.4	62.4	142	134	0	34	33
2015	7	19	19	54	8	0.663	-0.059	4.003	0.013	0.01	0	46.4	43.4	61.5	142	134	0	34	33
2015	7	19	20	4	8	0.705	-0.102	4.003	0.01	0.007	0	46	42.6	64.5	141	133	0	34	34
2015	7	19	20	14	8	0.692	-0.085	4.003	0.013	0.01	0	46.4	43.4	67.1	142	134	0	34	33
2015	7	19	20	24	8	0.656	-0.056	4.003	0.01	0.007	0	47.3	43.9	67.9	144	135	0	34	33
2015	7	19	20	34	8	0.692	-0.082	4.003	0.01	0.007	0	46.9	43.9	68.4	143	135	0	34	33
2015	7	19	20	44	8	0.686	-0.102	4.003	0.016	0.013	0	46	43.4	68.8	141	134	0	34	33
2015	7	19	20	54	8	0.712	-0.066	4.003	0.016	0.013	0	46.9	43.4	67.5	143	134	0	34	33
2015	7	19	21	4	8	0.676	-0.102	4.003	0.01	0.007	0	46.4	43	68.4	142	134	0	34	34
2015	7	19	21	14	8	0.686	-0.082	4.003	0.016	0.013	0	45.2	42.6	60.6	140	132	0	35	33
2015	7	19	21	24	8	0.696	-0.092	3.999	0.01	0.007	0	45.2	42.6	59.3	140	132	0	35	33
2015	7	19	21	34	8	0.705	-0.089	4.003	0.013	0.01	0	45.2	42.1	60.2	140	132	0	35	34
2015	7	19	21	44	8	0.682	-0.066	4.003	0.01	0.007	0	46	43	65.8	141	133	0	34	33
2015	7	19	21	54	8	0.686	-0.069	4.003	0.01	0.007	0	45.6	42.6	55	140	132	0	34	33
2015	7	19	22	4	8	0.689	-0.112	4.003	0.01	0.007	0	44.7	42.1	53.8	139	131	0	35	33
2015	7	19	22	14	8	0.702	-0.075	3.999	0.01	0.007	0	45.6	42.6	55.5	140	132	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	19	22	24	8	0.712	-0.079	4.003	0.013	0.01	0	45.6	43	52.9	140	133	0	34	33
2015	7	19	22	34	8	0.699	-0.062	4.003	0.01	0.007	0	45.6	42.6	61.9	140	132	0	34	33
2015	7	19	22	44	8	0.712	-0.082	4.003	0.013	0.01	0	45.6	42.1	62.4	140	132	0	34	34
2015	7	19	22	54	8	0.692	-0.075	4.003	0.013	0.01	0	45.6	43	60.2	140	132	0	34	32
2015	7	19	23	4	8	0.692	-0.082	4.003	0.013	0.01	0	46	43	62.8	141	133	0	34	33
2015	7	19	23	14	8	0.712	-0.085	4.003	0.013	0.01	0	45.2	42.6	69.7	140	132	0	35	33
2015	7	19	23	24	8	0.702	-0.102	4.003	0.013	0.01	0	45.2	42.6	60.6	140	132	0	35	33
2015	7	19	23	34	8	0.676	-0.095	4.003	0.01	0.007	0	45.6	43	61.9	140	132	0	34	32
2015	7	19	23	44	8	0.732	-0.095	4.003	0.013	0.01	0	44.3	42.1	55.9	138	131	0	35	33
2015	7	19	23	54	8	0.719	-0.108	3.999	0.01	0.007	0	45.6	42.6	53.8	140	132	0	34	33
2015	7	20	0	4	8	0.712	-0.066	4.003	0.01	0.007	0	46	43	63.2	141	133	0	34	33
2015	7	20	0	14	8	0.692	-0.066	4.003	0.01	0.007	0	45.6	42.1	68.8	140	131	0	34	33
2015	7	20	0	24	8	0.692	-0.118	4.003	0.01	0.007	0	45.2	42.1	65.4	139	131	0	34	33
2015	7	20	0	34	8	0.669	-0.098	4.003	0.01	0.007	0	46	43	46.4	141	133	0	34	33
2015	7	20	0	44	8	0.702	-0.059	4.006	0.01	0.007	0	52	49	49.5	155	147	0	34	33
2015	7	20	0	54	8	0.722	-0.03	4.006	0.016	0.013	0	52.9	50.3	59.8	157	150	0	34	33
2015	7	20	1	4	8	0.676	-0.069	4.006	0.016	0.016	0	51.6	48.6	59.3	155	147	0	35	34
2015	7	20	1	14	8	0.712	-0.085	4.006	0.01	0.007	0	50.7	47.3	56.3	152	144	0	34	34
2015	7	20	1	24	8	0.725	-0.066	4.006	0.01	0.007	0	50.3	47.3	60.2	151	143	0	34	33
2015	7	20	1	34	8	0.692	-0.062	4.006	0.01	0.007	0	49.5	46.4	64.1	149	141	0	34	33
2015	7	20	1	44	8	0.709	-0.075	4.006	0.01	0.007	0	48.6	46	63.6	147	139	0	34	32
2015	7	20	1	54	8	0.712	-0.059	4.006	0.01	0.007	0	47.7	44.7	62.8	145	137	0	34	33
2015	7	20	2	4	8	0.692	-0.085	4.006	0.013	0.01	0	47.3	44.7	64.9	144	136	0	34	32
2015	7	20	2	14	8	0.715	-0.072	4.009	0.013	0.01	0	46.9	43.9	63.2	143	135	0	34	33
2015	7	20	2	24	8	0.712	-0.089	4.009	0.013	0.01	0	46.9	43.9	62.4	143	135	0	34	33
2015	7	20	2	34	8	0.712	-0.062	4.009	0.01	0.007	0	46	43.9	62.4	142	135	0	35	33
2015	7	20	2	44	8	0.712	-0.062	4.009	0.013	0.01	0	46.4	43.4	65.4	142	134	0	34	33
2015	7	20	2	54	8	0.725	-0.075	4.009	0.01	0.007	0	46	43	67.5	141	133	0	34	33
2015	7	20	3	4	8	0.715	-0.089	4.009	0.01	0.007	0	46	43	67.1	141	133	0	34	33
2015	7	20	3	14	8	0.692	-0.066	4.009	0.013	0.01	0	45.6	43	64.9	140	133	0	34	33
2015	7	20	3	24	8	0.738	-0.079	4.009	0.01	0.007	0	46.4	43.4	65.4	142	133	0	34	32
2015	7	20	3	34	8	0.676	-0.079	4.009	0.01	0.007	0	45.2	42.1	68.4	139	131	0	34	33
2015	7	20	3	44	8	0.719	-0.118	4.009	0.016	0.013	0	46	42.6	68.8	140	132	0	33	33
2015	7	20	3	54	8	0.702	-0.092	4.009	0.01	0.007	0	45.2	43	68.4	140	132	0	35	32
2015	7	20	4	4	8	0.702	-0.066	4.009	0.01	0.007	0	46	43	68.4	141	133	0	34	33
2015	7	20	4	14	8	0.725	-0.082	4.009	0.01	0.007	0	46	43	69.2	141	133	0	34	33
2015	7	20	4	24	8	0.682	-0.072	4.009	0.01	0.007	0	44.7	42.1	63.2	139	132	0	35	34
2015	7	20	4	34	8	0.686	-0.075	4.009	0.01	0.007	0	45.6	42.6	66.2	140	132	0	34	33
2015	7	20	4	44	8	0.659	-0.056	4.009	0.016	0.013	0	45.6	42.6	59.8	140	132	0	34	33
2015	7	20	4	54	8	0.686	-0.092	4.009	0.013	0.01	0	44.7	42.1	57.6	138	131	0	34	33
2015	7	20	5	4	8	0.705	-0.072	4.009	0.01	0.007	0	46	42.6	64.5	141	133	0	34	34
2015	7	20	5	14	8	0.679	-0.102	4.009	0.01	0.007	0	45.6	42.6	63.2	140	132	0	34	33
2015	7	20	5	24	8	0.689	-0.072	4.009	0.013	0.01	0	45.2	42.6	64.1	140	132	0	35	33
2015	7	20	5	34	8	0.719	-0.085	4.009	0.013	0.01	0	45.6	42.6	62.4	140	132	0	34	33
2015	7	20	5	44	8	0.712	-0.098	4.009	0.016	0.013	0	45.6	42.6	63.6	140	132	0	34	33
2015	7	20	5	54	8	0.676	-0.112	4.009	0.013	0.01	0	46	42.1	67.1	140	131	0	33	33
2015	7	20	6	4	8	0.699	-0.118	4.009	0.01	0.007	0	45.2	42.1	69.7	139	131	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	20	6	14	8	0.692	-0.141	4.009	0.01	0.007	0	44.7	41.3	69.7	137	129	0	33	33
2015	7	20	6	24	8	0.722	-0.102	4.009	0.01	0.007	0	44.3	41.3	66.7	137	129	0	34	33
2015	7	20	6	34	8	0.705	-0.095	4.009	0.016	0.013	0	45.2	42.1	58.5	139	131	0	34	33
2015	7	20	6	44	8	0.696	-0.092	4.009	0.016	0.013	0	45.2	41.7	54.2	139	130	0	34	33
2015	7	20	6	54	8	0.702	-0.098	4.009	0.01	0.007	0	44.3	41.3	55.9	137	129	0	34	33
2015	7	20	7	4	8	0.689	-0.079	4.009	0.01	0.007	0	44.3	40.9	55	137	128	0	34	33
2015	7	20	7	14	8	0.692	-0.066	4.009	0.01	0.007	0	44.3	40.9	58.9	137	129	0	34	34
2015	7	20	7	24	8	0.692	-0.102	4.009	0.01	0.007	0	44.3	40.4	58.5	137	128	0	34	34
2015	7	20	7	34	8	0.689	-0.089	4.009	0.016	0.013	0	43.9	40.4	60.6	136	128	0	34	34
2015	7	20	7	44	8	0.692	-0.089	4.009	0.013	0.01	0	43.9	41.3	60.6	137	129	0	35	33
2015	7	20	7	54	8	0.702	-0.085	4.009	0.013	0.01	0	43.9	40.9	64.5	136	128	0	34	33
2015	7	20	8	4	8	0.719	-0.125	4.009	0.01	0.007	0	43.9	40.4	57.2	136	127	0	34	33
2015	7	20	8	14	8	0.696	-0.082	4.009	0.013	0.01	0	44.3	40.9	55.5	137	129	0	34	34
2015	7	20	8	24	8	0.689	-0.112	4.009	0.01	0.007	0	43.9	40.9	57.2	136	128	0	34	33
2015	7	20	8	34	8	0.709	-0.066	4.009	0.016	0.013	0	44.3	40.9	58	137	129	0	34	34
2015	7	20	8	44	8	0.699	-0.102	4.009	0.01	0.007	0	43.9	40.9	55	136	128	0	34	33
2015	7	20	8	54	8	0.686	-0.098	4.009	0.016	0.013	0	44.3	41.3	58	137	129	0	34	33
2015	7	20	9	4	8	0.702	-0.082	4.009	0.01	0.007	0	44.3	41.3	56.8	137	129	0	34	33
2015	7	20	9	14	8	0.689	-0.072	4.009	0.01	0.007	0	44.3	41.7	56.8	138	130	0	35	33
2015	7	20	9	24	8	0.702	-0.092	4.009	0.013	0.01	0	44.3	41.7	60.6	137	129	0	34	32
2015	7	20	9	34	8	0.709	-0.118	4.006	0.016	0.013	0	44.3	41.3	64.9	137	129	0	34	33
2015	7	20	9	44	8	0.705	-0.128	4.006	0.01	0.007	0	44.3	41.3	66.2	137	129	0	34	33
2015	7	20	9	54	8	0.728	-0.118	4.006	0.01	0.007	0	44.3	41.3	70.5	137	129	0	34	33
2015	7	20	10	4	8	0.673	-0.082	4.006	0.013	0.01	0	43.9	41.3	70.5	137	129	0	35	33
2015	7	20	10	14	8	0.692	-0.102	4.006	0.01	0.007	0	44.3	41.7	70.5	138	129	0	35	32
2015	7	20	10	24	8	0.725	-0.102	4.009	0.01	0.007	0	44.3	41.3	71	137	129	0	34	33
2015	7	20	10	34	8	0.699	-0.089	4.006	0.013	0.01	0	44.3	41.3	71	137	129	0	34	33
2015	7	20	10	44	8	0.732	-0.112	4.006	0.013	0.01	0	44.3	41.3	70.1	137	129	0	34	33
2015	7	20	10	54	8	0.715	-0.128	4.006	0.01	0.007	0	44.3	41.3	65.4	137	129	0	34	33
2015	7	20	11	4	8	0.673	-0.154	4.006	0.016	0.013	0	43.9	40.9	69.2	136	129	0	34	34
2015	7	20	11	14	8	0.676	-0.118	4.006	0.01	0.007	0	44.7	41.7	64.1	138	130	0	34	33
2015	7	20	11	24	8	0.705	-0.118	4.006	0.013	0.01	0	43.4	40.9	68.8	136	128	0	35	33
2015	7	20	11	34	8	0.699	-0.121	4.006	0.01	0.007	0	43.9	40.9	71	136	128	0	34	33
2015	7	20	11	44	8	0.702	-0.135	4.006	0.01	0.007	0	44.3	40.9	71.8	137	129	0	34	34
2015	7	20	11	54	8	0.709	-0.108	4.006	0.016	0.013	0	44.3	41.7	70.5	137	130	0	34	33
2015	7	20	12	4	8	0.705	-0.118	4.006	0.01	0.007	0	44.3	41.3	71.8	138	129	0	35	33
2015	7	20	12	14	8	0.666	-0.121	4.006	0.013	0.01	0	43.9	40.9	67.5	137	129	0	35	34
2015	7	20	12	24	8	0.686	-0.108	4.006	0.01	0.007	0	43.9	41.3	67.9	136	129	0	34	33
2015	7	20	12	34	8	0.682	-0.144	4.006	0.01	0.007	0	44.3	41.3	59.8	137	129	0	34	33
2015	7	20	12	44	8	0.702	-0.108	4.006	0.01	0.007	0	43.9	40.9	69.7	136	129	0	34	34
2015	7	20	12	54	8	0.696	-0.128	4.006	0.016	0.013	0	44.3	41.7	68.8	137	130	0	34	33
2015	7	20	13	4	8	0.715	-0.102	4.006	0.01	0.007	0	43.4	41.3	59.3	136	129	0	35	33
2015	7	20	13	14	8	0.659	-0.128	4.006	0.01	0.007	0	43.4	40.9	59.8	136	128	0	35	33
2015	7	20	13	24	8	0.696	-0.144	4.006	0.01	0.007	0	43.4	40.4	55.9	134	127	0	33	33
2015	7	20	13	34	8	0.705	-0.082	4.003	0.01	0.007	0	43.4	40.9	55.9	135	128	0	34	33
2015	7	20	13	44	8	0.699	-0.144	4.003	0.01	0.007	0	43.9	41.3	63.6	137	130	0	35	34
2015	7	20	13	54	8	0.692	-0.144	4.003	0.01	0.007	0	44.3	41.3	68.4	137	129	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	20	14	4	8	0.682	-0.151	4.003	0.01	0.007	0	43.9	41.7	68.8	137	130	0	35	33
2015	7	20	14	14	8	0.702	-0.141	4.003	0.01	0.007	0	44.3	41.3	63.2	137	129	0	34	33
2015	7	20	14	24	8	0.702	-0.141	4.003	0.013	0.01	0	43.4	41.3	53.8	136	129	0	35	33
2015	7	20	14	34	8	0.692	-0.138	4.003	0.01	0.007	0	43.9	41.3	56.3	137	129	0	35	33
2015	7	20	14	44	8	0.689	-0.105	4.003	0.016	0.013	0	43.9	41.7	64.9	136	129	0	34	32
2015	7	20	14	54	8	0.722	-0.135	4.003	0.013	0.01	0	43.4	40.9	63.6	136	128	0	35	33
2015	7	20	15	4	8	0.712	-0.131	4.003	0.01	0.007	0	43.9	41.3	58.9	136	129	0	34	33
2015	7	20	15	14	8	0.679	-0.118	4.003	0.01	0.007	0	44.3	41.3	68.8	137	129	0	34	33
2015	7	20	15	24	8	0.705	-0.151	3.999	0.01	0.007	0	44.3	40.9	63.6	137	129	0	34	34
2015	7	20	15	34	8	0.686	-0.118	4.003	0.016	0.013	0	44.3	41.3	69.7	137	129	0	34	33
2015	7	20	15	44	8	0.696	-0.098	4.003	0.01	0.007	0	44.3	42.1	65.8	137	130	0	34	32
2015	7	20	15	54	8	0.712	-0.059	3.999	0.01	0.007	0	44.7	41.7	61.1	138	130	0	34	33
2015	7	20	16	4	8	0.712	-0.069	3.999	0.016	0.016	0	45.2	42.1	70.1	139	131	0	34	33
2015	7	20	16	14	8	0.669	-0.082	3.999	0.01	0.007	0	45.2	42.1	69.7	139	131	0	34	33
2015	7	20	16	24	8	0.696	-0.125	3.999	0.013	0.01	0	43.9	41.7	69.2	137	130	0	35	33
2015	7	20	16	34	8	0.705	-0.112	3.999	0.016	0.013	0	44.7	41.7	69.7	138	130	0	34	33
2015	7	20	16	44	8	0.712	-0.098	3.999	0.013	0.01	0	45.2	42.6	70.1	139	132	0	34	33
2015	7	20	16	54	8	0.692	-0.102	3.999	0.01	0.007	0	45.2	41.7	69.7	139	131	0	34	34
2015	7	20	17	4	8	0.676	-0.095	3.999	0.01	0.007	0	44.7	42.6	69.7	139	132	0	35	33
2015	7	20	17	14	8	0.725	-0.082	3.999	0.01	0.007	0	44.7	41.7	70.1	138	130	0	34	33
2015	7	20	17	24	8	0.692	-0.105	3.999	0.01	0.007	0	45.2	42.1	66.2	139	131	0	34	33
2015	7	20	17	34	8	0.689	-0.105	3.999	0.01	0.007	0	44.7	42.1	67.5	138	131	0	34	33
2015	7	20	17	44	8	0.702	-0.131	3.999	0.01	0.007	0	43.9	41.7	67.5	137	130	0	35	33
2015	7	20	17	54	8	0.715	-0.121	3.999	0.01	0.007	0	44.7	41.7	59.8	138	130	0	34	33
2015	7	20	18	4	8	0.699	-0.105	3.999	0.013	0.01	0	45.2	42.6	68.8	139	131	0	34	32
2015	7	20	18	14	8	0.679	-0.108	3.999	0.013	0.01	0	44.7	41.7	70.1	138	130	0	34	33
2015	7	20	18	24	8	0.696	-0.075	3.999	0.013	0.01	0	44.7	41.7	69.2	138	130	0	34	33
2015	7	20	18	34	8	0.722	-0.082	3.999	0.013	0.01	0	45.2	42.6	69.2	139	132	0	34	33
2015	7	20	18	44	8	0.696	-0.102	3.999	0.01	0.007	0	44.7	41.7	69.2	138	130	0	34	33
2015	7	20	18	54	8	0.725	-0.102	3.999	0.01	0.007	0	44.7	41.7	65.4	138	130	0	34	33
2015	7	20	19	4	8	0.676	-0.089	3.999	0.01	0.007	0	45.2	42.1	60.2	139	131	0	34	33
2015	7	20	19	14	8	0.679	-0.092	3.999	0.01	0.007	0	44.7	41.7	62.8	138	130	0	34	33
2015	7	20	19	24	8	0.732	-0.082	3.999	0.01	0.007	0	44.3	41.7	68.4	138	130	0	35	33
2015	7	20	19	34	8	0.725	-0.085	3.999	0.01	0.007	0	44.7	41.3	65.8	137	129	0	33	33
2015	7	20	19	44	8	0.692	-0.059	3.999	0.013	0.01	0	45.2	42.1	68.8	139	131	0	34	33
2015	7	20	19	54	8	0.728	-0.089	3.999	0.01	0.007	0	45.2	41.7	69.2	139	131	0	34	34
2015	7	20	20	4	8	0.702	-0.092	3.999	0.013	0.01	0	45.2	41.7	61.9	139	131	0	34	34
2015	7	20	20	14	8	0.709	-0.115	4.003	0.013	0.01	0	45.6	43	62.8	140	132	0	34	32
2015	7	20	20	24	8	0.676	-0.118	4.003	0.01	0.007	0	45.6	42.6	70.1	140	132	0	34	33
2015	7	20	20	34	8	0.686	-0.082	4.003	0.01	0.007	0	46	43	67.9	141	133	0	34	33
2015	7	20	20	44	8	0.702	-0.102	4.003	0.013	0.01	0	46.4	43.4	67.1	142	134	0	34	33
2015	7	20	20	54	8	0.692	-0.069	4.003	0.01	0.007	0	46.9	43.9	65.8	143	135	0	34	33
2015	7	20	21	4	8	0.712	-0.082	4.003	0.01	0.007	0	46	43.4	66.7	141	133	0	34	32
2015	7	20	21	14	8	0.676	-0.112	4.003	0.01	0.007	0	45.6	43	67.9	140	133	0	34	33
2015	7	20	21	24	8	0.686	-0.066	4.003	0.013	0.01	0	45.6	43	68.4	140	133	0	34	33
2015	7	20	21	34	8	0.712	-0.098	4.003	0.01	0.007	0	46	43	69.7	141	133	0	34	33
2015	7	20	21	44	8	0.725	-0.085	4.003	0.01	0.007	0	45.6	42.6	69.2	140	132	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	20	21	54	8	0.669	-0.082	4.003	0.013	0.01	0	46	43	68.8	141	133	0	34	33
2015	7	20	22	4	8	0.692	-0.092	4.006	0.01	0.007	0	45.6	43	68.8	141	132	0	35	32
2015	7	20	22	14	8	0.699	-0.072	4.006	0.013	0.01	0	46	42.6	69.2	141	132	0	34	33
2015	7	20	22	24	8	0.682	-0.102	4.006	0.01	0.007	0	45.2	42.6	69.2	140	132	0	35	33
2015	7	20	22	34	8	0.666	-0.079	4.006	0.013	0.01	0	46	42.6	58	141	132	0	34	33
2015	7	20	22	44	8	0.699	-0.069	4.006	0.013	0.01	0	46	43	55	141	133	0	34	33
2015	7	20	22	54	8	0.725	-0.085	4.006	0.01	0.007	0	45.2	42.6	55.9	140	132	0	35	33
2015	7	20	23	4	8	0.715	-0.102	4.006	0.013	0.01	0	45.6	42.6	69.2	140	132	0	34	33
2015	7	20	23	14	8	0.709	-0.092	4.006	0.01	0.007	0	45.6	42.6	69.2	140	132	0	34	33
2015	7	20	23	24	8	0.679	-0.089	4.006	0.013	0.01	0	46	42.6	70.1	141	132	0	34	33
2015	7	20	23	34	8	0.692	-0.092	4.006	0.01	0.007	0	46	43	69.7	140	132	0	33	32
2015	7	20	23	44	8	0.692	-0.075	4.006	0.013	0.01	0	45.6	41.7	70.5	140	131	0	34	34
2015	7	20	23	54	8	0.656	-0.095	4.006	0.013	0.01	0	45.6	42.6	70.5	140	132	0	34	33
2015	7	21	0	4	8	0.719	-0.092	4.006	0.01	0.007	0	45.2	42.1	71.4	139	131	0	34	33
2015	7	21	0	14	8	0.679	-0.052	4.006	0.01	0.007	0	46.4	43	70.1	142	133	0	34	33
2015	7	21	0	24	8	0.679	-0.115	4.006	0.01	0.007	0	45.6	42.6	71	140	132	0	34	33
2015	7	21	0	34	8	0.699	-0.102	4.006	0.01	0.007	0	45.2	41.3	71	139	130	0	34	34
2015	7	21	0	44	8	0.699	-0.072	4.006	0.01	0.007	0	45.6	42.1	71.4	139	131	0	33	33
2015	7	21	0	54	8	0.719	-0.085	4.006	0.01	0.007	0	45.2	42.6	70.5	139	131	0	34	32
2015	7	21	1	4	8	0.682	-0.072	4.006	0.01	0.007	0	45.2	42.1	71	140	131	0	35	33
2015	7	21	1	14	8	0.705	-0.072	4.006	0.01	0.007	0	45.2	41.7	71	139	130	0	34	33
2015	7	21	1	24	8	0.689	-0.079	4.009	0.013	0.01	0	45.2	42.1	70.1	139	131	0	34	33
2015	7	21	1	34	8	0.699	-0.092	4.009	0.01	0.007	0	44.3	41.7	71	138	130	0	35	33
2015	7	21	1	44	8	0.696	-0.072	4.009	0.01	0.007	0	45.2	42.6	70.5	140	132	0	35	33
2015	7	21	1	54	8	0.705	-0.072	4.006	0.01	0.007	0	45.6	42.1	70.5	140	131	0	34	33
2015	7	21	2	4	8	0.692	-0.052	4.009	0.016	0.013	0	44.7	42.1	70.5	139	131	0	35	33
2015	7	21	2	14	8	0.702	-0.092	4.009	0.016	0.013	0	44.7	41.7	71.4	138	130	0	34	33
2015	7	21	2	24	8	0.686	-0.102	4.009	0.01	0.007	0	46	42.6	70.5	141	132	0	34	33
2015	7	21	2	34	8	0.669	-0.075	4.009	0.016	0.013	0	46	43.4	71.8	141	133	0	34	32
2015	7	21	2	44	8	0.689	-0.082	4.009	0.01	0.007	0	45.6	41.7	71	140	131	0	34	34
2015	7	21	2	54	8	0.696	-0.082	4.009	0.013	0.01	0	45.6	42.6	70.5	140	132	0	34	33
2015	7	21	3	4	8	0.692	-0.059	4.009	0.01	0.007	0	45.2	41.7	71	139	130	0	34	33
2015	7	21	3	14	8	0.679	-0.066	4.009	0.016	0.013	0	45.6	42.6	71	140	132	0	34	33
2015	7	21	3	24	8	0.699	-0.089	4.009	0.01	0.007	0	45.6	42.1	69.7	140	131	0	34	33
2015	7	21	3	34	8	0.696	-0.108	4.009	0.01	0.007	0	45.2	42.1	71	139	131	0	34	33
2015	7	21	3	44	8	0.659	-0.069	4.009	0.01	0.007	0	45.6	43	70.5	140	132	0	34	32
2015	7	21	3	54	8	0.712	-0.089	4.009	0.01	0.007	0	46	42.6	71	140	132	0	33	33
2015	7	21	4	4	8	0.696	-0.082	4.009	0.01	0.007	0	44.7	42.1	70.5	139	131	0	35	33
2015	7	21	4	14	8	0.709	-0.075	4.009	0.01	0.007	0	45.2	42.1	68.8	139	131	0	34	33
2015	7	21	4	24	8	0.692	-0.092	4.009	0.013	0.01	0	45.6	42.1	69.2	140	131	0	34	33
2015	7	21	4	34	8	0.696	-0.043	4.009	0.01	0.007	0	46	42.6	68.8	141	132	0	34	33
2015	7	21	4	44	8	0.692	-0.105	4.009	0.013	0.01	0	45.6	42.6	70.5	140	132	0	34	33
2015	7	21	4	54	8	0.715	-0.095	4.009	0.01	0.007	0	45.6	42.6	70.5	140	132	0	34	33
2015	7	21	5	4	8	0.692	-0.082	4.009	0.013	0.01	0	45.2	42.1	69.7	140	131	0	35	33
2015	7	21	5	14	8	0.715	-0.105	4.009	0.01	0.007	0	45.6	42.6	70.1	140	132	0	34	33
2015	7	21	5	24	8	0.712	-0.082	4.009	0.01	0.007	0	46.4	43	67.9	143	133	0	35	33
2015	7	21	5	34	8	0.686	-0.036	4.009	0.01	0.007	0	45.6	42.1	66.7	141	132	0	35	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	21	5	44	8	0.702	-0.098	4.009	0.01	0.007	0	45.6	42.6	70.1	141	132	0	35	33
2015	7	21	5	54	8	0.719	-0.092	4.009	0.01	0.007	0	45.2	41.7	69.7	139	130	0	34	33
2015	7	21	6	4	8	0.712	-0.052	4.009	0.01	0.007	0	45.2	42.1	70.1	139	130	0	34	32
2015	7	21	6	14	8	0.669	-0.069	4.009	0.013	0.01	0	45.2	41.7	69.7	139	130	0	34	33
2015	7	21	6	24	8	0.712	-0.098	4.009	0.013	0.01	0	44.7	41.7	69.2	139	130	0	35	33
2015	7	21	6	34	8	0.696	-0.098	4.009	0.016	0.013	0	44.7	41.7	69.7	139	130	0	35	33
2015	7	21	6	44	8	0.705	-0.089	4.009	0.01	0.007	0	44.7	41.7	70.1	138	130	0	34	33
2015	7	21	6	54	8	0.673	-0.082	4.009	0.01	0.007	0	45.2	41.3	69.2	139	129	0	34	33
2015	7	21	7	4	8	0.722	-0.095	4.012	0.01	0.007	0	44.3	41.3	70.1	138	129	0	35	33
2015	7	21	7	14	8	0.712	-0.098	4.009	0.01	0.007	0	44.3	40.9	69.2	137	128	0	34	33
2015	7	21	7	24	8	0.673	-0.102	4.012	0.013	0.01	0	44.7	41.3	70.1	138	129	0	34	33
2015	7	21	7	34	8	0.689	-0.062	4.012	0.01	0.007	0	44.3	41.3	69.7	137	129	0	34	33
2015	7	21	7	44	8	0.709	-0.079	4.012	0.01	0.007	0	44.3	41.7	69.2	137	129	0	34	32
2015	7	21	7	54	8	0.669	-0.066	4.012	0.013	0.01	0	44.7	41.7	69.2	138	129	0	34	32
2015	7	21	8	4	8	0.705	-0.066	4.012	0.013	0.01	0	44.7	41.3	69.7	138	130	0	34	34
2015	7	21	8	14	8	0.735	-0.098	4.012	0.01	0.007	0	44.7	41.3	68.4	138	129	0	34	33
2015	7	21	8	24	8	0.692	-0.082	4.012	0.01	0.007	0	44.3	41.3	70.1	137	129	0	34	33
2015	7	21	8	34	8	0.696	-0.069	4.012	0.013	0.01	0	44.7	41.7	69.2	138	130	0	34	33
2015	7	21	8	44	8	0.696	-0.085	4.012	0.01	0.007	0	44.3	41.3	69.2	138	129	0	35	33
2015	7	21	8	54	8	0.679	-0.098	4.012	0.01	0.007	0	44.7	41.3	69.2	138	129	0	34	33
2015	7	21	9	4	8	0.692	-0.108	4.012	0.013	0.01	0	45.2	42.1	67.9	139	131	0	34	33
2015	7	21	9	14	8	0.699	-0.102	4.012	0.013	0.01	0	44.3	41.3	69.7	137	129	0	34	33
2015	7	21	9	24	8	0.692	-0.098	4.012	0.01	0.007	0	44.3	41.7	69.7	138	130	0	35	33
2015	7	21	9	34	8	0.679	-0.092	4.012	0.01	0.007	0	44.7	41.7	69.2	138	130	0	34	33
2015	7	21	9	44	8	0.735	-0.102	4.012	0.013	0.01	0	44.7	41.7	64.5	138	130	0	34	33
2015	7	21	9	54	8	0.738	-0.144	4.012	0.013	0.01	0	44.3	41.3	64.9	137	129	0	34	33
2015	7	21	10	4	8	0.712	-0.118	4.012	0.013	0.01	0	43.9	40.9	67.1	136	128	0	34	33
2015	7	21	10	14	8	0.725	-0.131	4.012	0.013	0.01	0	43.9	40.9	67.5	136	128	0	34	33
2015	7	21	10	24	8	0.696	-0.125	4.012	0.016	0.013	0	44.3	41.7	58	137	129	0	34	32
2015	7	21	10	34	8	0.689	-0.135	4.016	0.01	0.007	0	44.7	41.7	53.8	138	130	0	34	33
2015	7	21	10	44	8	0.699	-0.095	4.012	0.01	0.007	0	44.3	41.7	62.4	137	129	0	34	32
2015	7	21	10	54	8	0.689	-0.118	4.012	0.01	0.007	0	44.7	41.7	55.5	138	129	0	34	32
2015	7	21	11	4	8	0.715	-0.121	4.012	0.01	0.007	0	44.3	41.3	69.7	137	129	0	34	33
2015	7	21	11	14	8	0.712	-0.141	4.012	0.01	0.007	0	43.9	41.3	64.5	136	128	0	34	32
2015	7	21	11	24	8	0.696	-0.112	4.012	0.013	0.01	0	44.3	41.7	57.6	138	130	0	35	33
2015	7	21	11	34	8	0.696	-0.118	4.012	0.01	0.007	0	43.9	41.3	70.5	136	129	0	34	33
2015	7	21	11	44	8	0.728	-0.128	4.012	0.01	0.007	0	43.9	41.3	66.2	136	129	0	34	33
2015	7	21	11	54	8	0.712	-0.108	4.012	0.01	0.007	0	43.9	41.7	56.8	137	130	0	35	33
2015	7	21	12	4	8	0.712	-0.105	4.012	0.013	0.01	0	44.7	41.7	62.8	138	130	0	34	33
2015	7	21	12	14	8	0.696	-0.135	4.012	0.013	0.01	0	44.3	41.7	71	137	129	0	34	32
2015	7	21	12	24	8	0.696	-0.125	4.012	0.01	0.007	0	44.7	41.7	55.9	138	130	0	34	33
2015	7	21	12	34	8	0.682	-0.118	4.012	0.01	0.007	0	43.9	40.9	64.5	136	128	0	34	33
2015	7	21	12	44	8	0.682	-0.161	4.012	0.013	0.01	0	43.9	40.4	60.2	136	127	0	34	33
2015	7	21	12	54	8	0.709	-0.151	4.012	0.01	0.007	0	43.9	40.9	62.4	136	128	0	34	33
2015	7	21	13	4	8	0.669	-0.148	4.009	0.01	0.007	0	43.9	41.3	66.7	136	128	0	34	32
2015	7	21	13	14	8	0.702	-0.125	4.012	0.013	0.01	0	43.9	41.3	55	136	129	0	34	33
2015	7	21	13	24	8	0.696	-0.102	4.012	0.013	0.01	0	43.4	41.3	54.2	136	128	0	35	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	21	13	34	8	0.705	-0.121	4.009	0.01	0.007	0	43.9	40.9	56.3	136	128	0	34	33
2015	7	21	13	44	8	0.709	-0.131	4.009	0.013	0.01	0	43.9	40.9	61.1	136	128	0	34	33
2015	7	21	13	54	8	0.705	-0.151	4.009	0.01	0.007	0	43.4	40.9	60.2	135	128	0	34	33
2015	7	21	14	4	8	0.696	-0.135	4.009	0.01	0.007	0	43.4	40.9	69.7	135	128	0	34	33
2015	7	21	14	14	8	0.692	-0.108	4.009	0.013	0.01	0	44.3	41.7	60.2	137	129	0	34	32
2015	7	21	14	24	8	0.689	-0.128	4.009	0.013	0.01	0	43.4	40.9	63.6	135	128	0	34	33
2015	7	21	14	34	8	0.722	-0.112	4.009	0.01	0.007	0	43.4	41.3	52.9	136	128	0	35	32
2015	7	21	14	44	8	0.692	-0.118	4.009	0.01	0.007	0	44.3	41.3	51.2	137	129	0	34	33
2015	7	21	14	54	8	0.682	-0.128	4.009	0.013	0.01	0	43.9	41.3	54.6	136	128	0	34	32
2015	7	21	15	4	8	0.696	-0.102	4.009	0.01	0.007	0	43.9	40.9	59.8	136	128	0	34	33
2015	7	21	15	14	8	0.692	-0.135	4.009	0.01	0.007	0	43.4	40.9	62.8	136	128	0	35	33
2015	7	21	15	24	8	0.712	-0.118	4.009	0.013	0.01	0	43.9	40.9	54.6	136	128	0	34	33
2015	7	21	15	34	8	0.696	-0.112	4.009	0.016	0.013	0	44.3	41.3	58.9	137	129	0	34	33
2015	7	21	15	44	8	0.715	-0.118	4.009	0.01	0.007	0	43.9	40.9	69.7	136	128	0	34	33
2015	7	21	15	54	8	0.715	-0.151	4.006	0.01	0.007	0	44.3	41.3	60.6	137	129	0	34	33
2015	7	21	16	4	8	0.725	-0.118	4.006	0.016	0.013	0	44.3	41.7	55.9	137	130	0	34	33
2015	7	21	16	14	8	0.705	-0.072	4.006	0.01	0.007	0	44.3	41.7	59.3	137	130	0	34	33
2015	7	21	16	24	8	0.719	-0.148	4.006	0.01	0.007	0	44.7	41.7	61.1	138	130	0	34	33
2015	7	21	16	34	8	0.696	-0.141	4.009	0.01	0.007	0	44.3	41.3	71.8	137	129	0	34	33
2015	7	21	16	44	8	0.702	-0.115	4.006	0.013	0.01	0	44.7	41.7	61.1	138	130	0	34	33
2015	7	21	16	54	8	0.712	-0.102	4.006	0.01	0.007	0	44.3	41.7	64.1	138	130	0	35	33
2015	7	21	17	4	8	0.715	-0.135	4.009	0.013	0.01	0	44.3	41.7	71	137	130	0	34	33
2015	7	21	17	14	8	0.715	-0.112	4.009	0.01	0.007	0	44.7	42.1	71.8	139	131	0	35	33
2015	7	21	17	24	8	0.702	-0.085	4.009	0.01	0.007	0	44.3	41.7	69.2	138	130	0	35	33
2015	7	21	17	34	8	0.689	-0.102	4.009	0.01	0.007	0	45.2	42.1	58	139	131	0	34	33
2015	7	21	17	44	8	0.692	-0.092	4.009	0.01	0.007	0	45.6	42.6	62.4	140	132	0	34	33
2015	7	21	17	54	8	0.712	-0.079	4.009	0.01	0.007	0	45.2	42.1	65.4	139	131	0	34	33
2015	7	21	18	4	8	0.702	-0.069	4.009	0.016	0.013	0	45.6	42.6	67.9	140	131	0	34	32
2015	7	21	18	14	8	0.676	-0.092	4.009	0.013	0.01	0	44.7	42.6	65.8	138	131	0	34	32
2015	7	21	18	24	8	0.699	-0.072	4.009	0.013	0.01	0	45.2	42.1	64.9	139	131	0	34	33
2015	7	21	18	34	8	0.705	-0.121	4.009	0.013	0.01	0	45.2	41.7	66.2	138	130	0	33	33
2015	7	21	18	44	8	0.699	-0.082	4.009	0.016	0.013	0	45.6	42.1	67.1	140	131	0	34	33
2015	7	21	18	54	8	0.705	-0.105	4.009	0.016	0.013	0	45.2	42.1	68.8	139	130	0	34	32
2015	7	21	19	4	8	0.702	-0.082	4.009	0.01	0.007	0	45.2	42.1	67.5	139	131	0	34	33
2015	7	21	19	14	8	0.715	-0.052	4.009	0.016	0.016	0	45.6	42.6	57.6	140	131	0	34	32
2015	7	21	19	24	8	0.689	-0.072	4.012	0.01	0.007	0	46.4	42.6	53.8	142	132	0	34	33
2015	7	21	19	34	8	0.712	-0.102	4.009	0.01	0.007	0	47.3	44.3	67.9	144	135	0	34	32
2015	7	21	19	44	8	0.712	-0.089	4.009	0.016	0.013	0	47.3	44.3	66.7	144	136	0	34	33
2015	7	21	19	54	8	0.699	-0.085	4.012	0.01	0.007	0	47.7	43.9	67.1	144	135	0	33	33
2015	7	21	20	4	8	0.715	-0.072	4.012	0.01	0.007	0	47.3	45.2	69.7	145	137	0	35	32
2015	7	21	20	14	8	0.673	-0.016	4.012	0.01	0.007	0	47.7	44.3	63.2	145	136	0	34	33
2015	7	21	20	24	8	0.696	-0.069	4.012	0.013	0.01	0	47.7	44.7	67.9	145	137	0	34	33
2015	7	21	20	34	8	0.692	-0.085	4.012	0.01	0.007	0	47.7	44.3	68.4	144	136	0	33	33
2015	7	21	20	44	8	0.689	-0.052	4.012	0.013	0.01	0	48.2	45.2	67.1	146	137	0	34	32
2015	7	21	20	54	8	0.712	-0.089	4.012	0.01	0.007	0	47.3	44.7	64.9	144	136	0	34	32
2015	7	21	21	4	8	0.676	-0.085	4.012	0.01	0.007	0	46.9	43.9	65.4	143	135	0	34	33
2015	7	21	21	14	8	0.709	-0.085	4.012	0.01	0.007	0	46.4	43.4	67.5	141	133	0	33	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	21	21	24	8	0.709	-0.098	4.012	0.01	0.007	0	46	43	67.5	141	133	0	34	33
2015	7	21	21	34	8	0.682	-0.052	4.012	0.016	0.016	0	46.4	43.9	68.8	142	134	0	34	32
2015	7	21	21	44	8	0.699	-0.085	4.012	0.013	0.01	0	46	43	69.2	141	133	0	34	33
2015	7	21	21	54	8	0.686	-0.085	4.016	0.01	0.007	0	46	42.6	69.2	141	132	0	34	33
2015	7	21	22	4	8	0.712	-0.102	4.016	0.01	0.007	0	45.6	42.6	70.5	140	132	0	34	33
2015	7	21	22	14	8	0.682	-0.089	4.016	0.01	0.007	0	46.4	43.9	70.1	142	134	0	34	32
2015	7	21	22	24	8	0.682	-0.085	4.016	0.016	0.013	0	45.6	43	69.7	141	133	0	35	33
2015	7	21	22	34	8	0.686	-0.075	4.016	0.01	0.007	0	46	43	70.5	141	133	0	34	33
2015	7	21	22	44	8	0.692	-0.082	4.016	0.016	0.013	0	45.6	42.6	69.7	140	131	0	34	32
2015	7	21	22	54	8	0.712	-0.062	4.016	0.013	0.01	0	45.6	42.6	67.1	140	132	0	34	33
2015	7	21	23	4	8	0.702	-0.082	4.016	0.01	0.007	0	46	42.6	70.5	141	132	0	34	33
2015	7	21	23	14	8	0.702	-0.095	4.016	0.013	0.01	0	45.6	42.6	69.2	140	132	0	34	33
2015	7	21	23	24	8	0.728	-0.089	4.016	0.01	0.007	0	45.2	42.1	68.8	139	131	0	34	33
2015	7	21	23	34	8	0.715	-0.082	4.019	0.01	0.007	0	44.7	41.7	70.5	138	130	0	34	33
2015	7	21	23	44	8	0.709	-0.085	4.019	0.01	0.007	0	45.2	43	69.7	140	132	0	35	32
2015	7	21	23	54	8	0.709	-0.082	4.019	0.016	0.013	0	45.6	42.6	69.7	140	132	0	34	33
2015	7	22	0	4	8	0.699	-0.049	4.019	0.01	0.007	0	45.2	42.1	68.4	139	131	0	34	33
2015	7	22	0	14	8	0.689	-0.102	4.019	0.01	0.007	0	46	42.1	70.1	140	131	0	33	33
2015	7	22	0	24	8	0.702	-0.092	4.019	0.016	0.013	0	45.2	42.1	69.2	139	131	0	34	33
2015	7	22	0	34	8	0.682	-0.069	4.019	0.016	0.013	0	46	42.6	69.7	141	132	0	34	33
2015	7	22	0	44	8	0.679	-0.089	4.019	0.01	0.007	0	45.6	42.1	69.2	140	131	0	34	33
2015	7	22	0	54	8	0.692	-0.059	4.019	0.01	0.007	0	45.6	42.1	69.2	139	131	0	33	33
2015	7	22	1	4	8	0.705	-0.089	4.019	0.01	0.007	0	44.7	41.7	69.2	138	130	0	34	33
2015	7	22	1	14	8	0.673	-0.095	4.019	0.01	0.007	0	45.2	42.6	68.4	139	131	0	34	32
2015	7	22	1	24	8	0.669	-0.082	4.019	0.01	0.007	0	45.2	42.1	68.8	139	131	0	34	33
2015	7	22	1	34	8	0.715	-0.108	4.022	0.013	0.01	0	44.7	41.7	69.2	138	130	0	34	33
2015	7	22	1	44	8	0.679	-0.092	4.022	0.01	0.007	0	46	43	69.2	141	132	0	34	32
2015	7	22	1	54	8	0.679	-0.098	4.022	0.01	0.007	0	45.6	42.1	68.8	140	131	0	34	33
2015	7	22	2	4	8	0.689	-0.069	4.022	0.01	0.007	0	45.6	42.1	68.4	140	131	0	34	33
2015	7	22	2	14	8	0.705	-0.121	4.022	0.01	0.007	0	44.7	42.1	68.4	138	130	0	34	32
2015	7	22	2	24	8	0.669	-0.082	4.022	0.016	0.013	0	45.2	42.1	68.4	139	131	0	34	33
2015	7	22	2	34	8	0.709	-0.092	4.022	0.01	0.007	0	45.6	42.1	68.4	140	131	0	34	33
2015	7	22	2	44	8	0.725	-0.085	4.022	0.01	0.007	0	45.2	42.1	68.8	139	131	0	34	33
2015	7	22	2	54	8	0.692	-0.059	4.022	0.016	0.013	0	46	42.6	67.9	141	132	0	34	33
2015	7	22	3	4	8	0.689	-0.079	4.022	0.01	0.007	0	46	43	67.1	141	133	0	34	33
2015	7	22	3	14	8	0.702	-0.069	4.022	0.013	0.01	0	45.2	42.6	67.1	140	132	0	35	33
2015	7	22	3	24	8	0.692	-0.082	4.022	0.013	0.01	0	45.6	42.6	67.1	140	132	0	34	33
2015	7	22	3	34	8	0.702	-0.069	4.026	0.01	0.007	0	45.6	42.1	66.7	140	132	0	34	34
2015	7	22	3	44	8	0.732	-0.098	4.026	0.013	0.01	0	46	43	66.2	141	133	0	34	33
2015	7	22	3	54	8	0.712	-0.056	4.026	0.01	0.007	0	45.2	42.6	66.2	140	132	0	35	33
2015	7	22	4	4	8	0.646	-0.046	4.029	0.01	0.007	0	46.4	43.4	66.2	142	134	0	34	33
2015	7	22	4	14	8	0.702	-0.069	4.032	0.01	0.007	0	45.2	43	66.7	140	132	0	35	32
2015	7	22	4	24	8	0.676	-0.052	4.032	0.013	0.01	0	46.4	43.4	66.7	142	134	0	34	33
2015	7	22	4	34	8	0.715	-0.056	4.035	0.01	0.007	0	45.6	42.1	67.5	140	131	0	34	33
2015	7	22	4	44	8	0.709	-0.082	4.035	0.013	0.01	0	45.6	42.6	67.9	140	132	0	34	33
2015	7	22	4	54	8	0.715	-0.102	4.035	0.01	0.007	0	46	43	67.1	141	133	0	34	33
2015	7	22	5	4	8	0.696	-0.069	4.035	0.01	0.007	0	46	43	67.5	141	133	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	22	5	14	8	0.719	-0.102	4.039	0.016	0.013	0	45.6	43.4	67.9	141	133	0	35	32
2015	7	22	5	24	8	0.676	-0.085	4.039	0.013	0.01	0	46	43	67.5	141	133	0	34	33
2015	7	22	5	34	8	0.732	-0.079	4.039	0.01	0.007	0	45.2	42.6	67.5	140	132	0	35	33
2015	7	22	5	44	8	0.712	-0.082	4.039	0.013	0.01	0	45.2	42.1	68.4	139	131	0	34	33
2015	7	22	5	54	8	0.686	-0.069	4.039	0.01	0.007	0	46	42.6	68.4	140	132	0	33	33
2015	7	22	6	4	8	0.669	-0.069	4.039	0.01	0.007	0	45.2	42.1	68.4	139	131	0	34	33
2015	7	22	6	14	8	0.722	-0.079	4.039	0.016	0.013	0	45.2	42.1	69.7	139	131	0	34	33
2015	7	22	6	24	8	0.692	-0.072	4.039	0.01	0.007	0	44.7	41.7	70.1	138	130	0	34	33
2015	7	22	6	34	8	0.659	-0.089	4.039	0.01	0.007	0	44.7	42.1	69.2	138	130	0	34	32
2015	7	22	6	44	8	0.696	-0.069	4.042	0.013	0.01	0	44.7	41.7	70.1	138	130	0	34	33
2015	7	22	6	54	8	0.689	-0.121	4.042	0.013	0.01	0	44.3	41.7	69.2	137	129	0	34	32
2015	7	22	7	4	8	0.686	-0.075	4.042	0.013	0.01	0	44.3	41.3	64.5	137	129	0	34	33
2015	7	22	7	14	8	0.705	-0.112	4.042	0.01	0.007	0	44.3	41.7	70.1	137	129	0	34	32
2015	7	22	7	24	8	0.702	-0.075	4.042	0.01	0.007	0	44.3	41.3	71	137	129	0	34	33
2015	7	22	7	34	8	0.728	-0.082	4.042	0.016	0.016	0	44.3	41.3	70.5	137	129	0	34	33
2015	7	22	7	44	8	0.712	-0.079	4.042	0.01	0.007	0	44.3	41.7	69.7	137	130	0	34	33
2015	7	22	7	54	8	0.699	-0.072	4.042	0.01	0.007	0	45.2	42.6	70.5	139	131	0	34	32
2015	7	22	8	4	8	0.696	-0.082	4.042	0.01	0.007	0	44.7	41.7	70.5	138	130	0	34	33
2015	7	22	8	14	8	0.673	-0.089	4.042	0.013	0.01	0	44.7	42.1	69.7	138	131	0	34	33
2015	7	22	8	24	8	0.712	-0.085	4.042	0.016	0.013	0	44.7	41.7	70.1	138	130	0	34	33
2015	7	22	8	34	8	0.705	-0.089	4.042	0.016	0.013	0	44.7	42.1	69.7	138	131	0	34	33
2015	7	22	8	44	8	0.712	-0.115	4.042	0.01	0.007	0	44.7	41.7	70.1	138	130	0	34	33
2015	7	22	8	54	8	0.686	-0.075	4.042	0.01	0.007	0	44.7	41.7	71	138	130	0	34	33
2015	7	22	9	4	8	0.676	-0.092	4.042	0.01	0.007	0	44.7	41.3	71.4	138	130	0	34	34
2015	7	22	9	14	8	0.738	-0.089	4.042	0.01	0.007	0	44.7	41.7	69.7	138	130	0	34	33
2015	7	22	9	24	8	0.705	-0.112	4.042	0.01	0.007	0	44.3	41.7	71	137	129	0	34	32
2015	7	22	9	34	8	0.712	-0.105	4.042	0.01	0.007	0	44.7	41.3	61.9	138	130	0	34	34
2015	7	22	9	44	8	0.725	-0.118	4.042	0.01	0.007	0	44.3	41.7	59.3	137	130	0	34	33
2015	7	22	9	54	8	0.745	-0.118	4.042	0.013	0.01	0	44.3	41.3	64.9	137	130	0	34	34
2015	7	22	10	4	8	0.699	-0.144	4.042	0.01	0.007	0	44.3	41.3	67.5	137	129	0	34	33
2015	7	22	10	14	8	0.696	-0.135	4.042	0.01	0.007	0	44.3	42.1	64.5	137	130	0	34	32
2015	7	22	10	24	8	0.709	-0.138	4.042	0.01	0.007	0	44.3	40.9	57.6	137	129	0	34	34
2015	7	22	10	34	8	0.722	-0.128	4.042	0.013	0.01	0	44.7	41.7	69.7	138	130	0	34	33
2015	7	22	10	44	8	0.725	-0.135	4.042	0.01	0.007	0	44.3	41.7	67.9	137	130	0	34	33
2015	7	22	10	54	8	0.696	-0.131	4.042	0.013	0.01	0	43.9	41.3	59.8	136	129	0	34	33
2015	7	22	11	4	8	0.725	-0.125	4.042	0.01	0.007	0	45.2	41.7	56.3	139	131	0	34	34
2015	7	22	11	14	8	0.689	-0.138	4.042	0.013	0.01	0	44.3	41.7	49.5	138	130	0	35	33
2015	7	22	11	24	8	0.699	-0.085	4.042	0.01	0.007	0	45.6	42.6	48.2	140	132	0	34	33
2015	7	22	11	34	8	0.692	-0.141	4.039	0.013	0.01	0	44.7	41.3	50.7	138	130	0	34	34
2015	7	22	11	44	8	0.699	-0.128	4.039	0.01	0.007	0	44.7	41.3	51.6	138	129	0	34	33
2015	7	22	11	54	8	0.692	-0.151	4.039	0.013	0.01	0	44.7	41.3	45.6	138	129	0	34	33
2015	7	22	12	4	8	0.712	-0.075	4.039	0.013	0.01	0	45.2	42.1	50.3	139	131	0	34	33
2015	7	22	12	14	8	0.692	-0.125	4.039	0.01	0.007	0	44.7	42.1	49.9	138	130	0	34	32
2015	7	22	12	24	8	0.692	-0.151	4.039	0.01	0.007	0	44.3	41.3	49.5	137	129	0	34	33
2015	7	22	12	34	8	0.709	-0.108	4.039	0.01	0.007	0	45.2	42.1	48.6	139	131	0	34	33
2015	7	22	12	44	8	0.728	-0.075	4.039	0.01	0.007	0	45.2	42.6	47.7	139	132	0	34	33
2015	7	22	12	54	8	0.656	-0.105	4.035	0.01	0.007	0	44.7	41.7	49.5	138	130	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	22	13	4	8	0.712	-0.135	4.035	0.013	0.01	0	45.2	41.7	48.6	139	131	0	34	34
2015	7	22	13	14	8	0.702	-0.108	4.035	0.01	0.007	0	45.2	42.6	48.6	139	132	0	34	33
2015	7	22	13	24	8	0.699	-0.095	4.035	0.013	0.01	0	45.2	43	49.5	140	132	0	35	32
2015	7	22	13	34	8	0.699	-0.138	4.035	0.01	0.007	0	44.7	42.1	47.7	138	131	0	34	33
2015	7	22	13	44	8	0.653	-0.148	4.035	0.013	0.01	0	44.7	41.7	47.7	138	130	0	34	33
2015	7	22	13	54	8	0.722	-0.089	4.035	0.016	0.013	0	45.6	42.1	48.2	139	131	0	33	33
2015	7	22	14	4	8	0.696	-0.125	4.035	0.013	0.01	0	45.2	42.1	47.7	139	131	0	34	33
2015	7	22	14	14	8	0.689	-0.082	4.035	0.01	0.007	0	45.6	43	47.7	140	132	0	34	32
2015	7	22	14	24	8	0.682	-0.102	4.032	0.01	0.007	0	46	42.6	49.5	140	132	0	33	33
2015	7	22	14	34	8	0.653	-0.098	4.035	0.016	0.013	0	45.6	42.6	49.9	140	132	0	34	33
2015	7	22	14	44	8	0.669	-0.059	4.029	0.013	0.01	0	45.2	43	49.5	140	132	0	35	32
2015	7	22	14	54	8	0.689	-0.151	4.032	0.01	0.007	0	45.6	42.6	47.3	140	132	0	34	33
2015	7	22	15	4	8	0.689	-0.072	4.032	0.01	0.007	0	45.6	42.1	49.9	140	132	0	34	34
2015	7	22	15	14	8	0.689	-0.112	4.032	0.013	0.01	0	45.6	42.6	48.6	140	132	0	34	33
2015	7	22	15	24	8	0.682	-0.112	4.032	0.01	0.007	0	45.2	42.1	47.7	139	131	0	34	33
2015	7	22	15	34	8	0.725	-0.102	4.032	0.016	0.013	0	45.6	42.1	48.6	140	132	0	34	34
2015	7	22	15	44	8	0.702	-0.141	4.029	0.013	0.01	0	45.6	42.6	48.2	140	132	0	34	33
2015	7	22	15	54	8	0.676	-0.135	4.026	0.013	0.01	0	45.6	42.6	48.2	139	132	0	33	33
2015	7	22	16	4	8	0.676	-0.085	4.032	0.013	0.01	0	44.7	42.6	49	139	132	0	35	33
2015	7	22	16	14	8	0.676	-0.092	4.029	0.013	0.01	0	45.6	43	47.3	140	133	0	34	33
2015	7	22	16	24	8	0.696	-0.102	4.029	0.01	0.007	0	45.6	42.1	48.2	140	132	0	34	34
2015	7	22	16	34	8	0.696	-0.102	4.029	0.016	0.013	0	46	43.4	49.5	141	133	0	34	32
2015	7	22	16	44	8	0.715	-0.079	4.029	0.01	0.007	0	45.2	42.6	49.5	139	132	0	34	33
2015	7	22	16	54	8	0.715	-0.115	4.029	0.013	0.01	0	45.2	43	47.3	139	132	0	34	32
2015	7	22	17	4	8	0.719	-0.066	4.029	0.013	0.01	0	45.6	43.4	50.3	140	133	0	34	32
2015	7	22	17	14	8	0.702	-0.075	4.026	0.01	0.007	0	45.2	42.6	46.9	139	132	0	34	33
2015	7	22	17	24	8	0.705	-0.069	4.029	0.013	0.01	0	45.2	42.6	47.7	139	132	0	34	33
2015	7	22	17	34	8	0.712	-0.092	4.029	0.01	0.007	0	44.7	42.1	51.2	139	131	0	35	33
2015	7	22	17	44	8	0.699	-0.095	4.026	0.01	0.007	0	45.2	42.6	50.7	139	132	0	34	33
2015	7	22	17	54	8	0.705	-0.052	4.029	0.013	0.01	0	45.6	42.1	51.2	139	131	0	33	33
2015	7	22	18	4	8	0.699	-0.144	4.026	0.013	0.01	0	44.3	41.3	49	137	129	0	34	33
2015	7	22	18	14	8	0.712	-0.121	4.029	0.01	0.007	0	43.9	41.3	47.3	136	129	0	34	33
2015	7	22	18	24	8	0.712	-0.105	4.029	0.01	0.007	0	44.3	40.9	47.7	137	129	0	34	34
2015	7	22	18	34	8	0.689	-0.069	4.026	0.013	0.01	0	45.2	42.1	49.9	139	131	0	34	33
2015	7	22	18	44	8	0.705	-0.102	4.029	0.01	0.007	0	44.7	42.1	47.3	138	131	0	34	33
2015	7	22	18	54	8	0.715	-0.095	4.026	0.01	0.007	0	44.7	42.1	49.9	138	131	0	34	33
2015	7	22	19	4	8	0.715	-0.105	4.026	0.016	0.013	0	44.7	41.7	48.2	138	130	0	34	33
2015	7	22	19	14	8	0.715	-0.118	4.029	0.01	0.007	0	44.3	40.9	47.3	137	129	0	34	34
2015	7	22	19	24	8	0.702	-0.066	4.026	0.013	0.01	0	45.2	42.1	50.3	139	131	0	34	33
2015	7	22	19	34	8	0.705	-0.102	4.029	0.01	0.007	0	45.2	42.1	48.2	139	131	0	34	33
2015	7	22	19	44	8	0.732	-0.079	4.029	0.01	0.007	0	44.7	41.7	53.8	138	130	0	34	33
2015	7	22	19	54	8	0.732	-0.128	4.022	0.01	0.007	0	45.2	42.6	54.6	140	132	0	35	33
2015	7	22	20	4	8	0.705	-0.128	4.026	0.013	0.01	0	45.6	43	55	140	132	0	34	32
2015	7	22	20	14	8	0.699	-0.085	4.029	0.013	0.01	0	46	43.4	50.3	141	133	0	34	32
2015	7	22	20	24	8	0.689	-0.112	4.026	0.01	0.007	0	46.4	43	52.9	142	133	0	34	33
2015	7	22	20	34	8	0.692	-0.085	4.029	0.01	0.007	0	46.4	43.4	49.5	142	133	0	34	32
2015	7	22	20	44	8	0.692	-0.102	4.029	0.01	0.007	0	46.4	43.4	49.5	142	134	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	22	20	54	8	0.712	-0.089	4.029	0.013	0.01	0	46	43	49.5	141	133	0	34	33
2015	7	22	21	4	8	0.689	-0.135	4.026	0.013	0.01	0	46	42.6	51.6	141	132	0	34	33
2015	7	22	21	14	8	0.709	-0.059	4.029	0.01	0.007	0	46.4	43.4	52.9	142	134	0	34	33
2015	7	22	21	24	8	0.722	-0.102	4.026	0.016	0.013	0	45.2	42.1	61.1	139	131	0	34	33
2015	7	22	21	34	8	0.692	-0.082	4.026	0.01	0.007	0	46	43	65.8	141	133	0	34	33
2015	7	22	21	44	8	0.699	-0.085	4.026	0.01	0.007	0	45.2	42.6	65.8	139	132	0	34	33
2015	7	22	21	54	8	0.682	-0.102	4.029	0.013	0.01	0	45.6	42.1	64.9	139	131	0	33	33
2015	7	22	22	4	8	0.699	-0.118	4.029	0.01	0.007	0	46	43	65.8	141	133	0	34	33
2015	7	22	22	14	8	0.696	-0.039	4.029	0.01	0.007	0	46	43.9	66.2	141	134	0	34	32
2015	7	22	22	24	8	0.696	-0.082	4.032	0.013	0.01	0	45.6	42.6	65.8	140	132	0	34	33
2015	7	22	22	34	8	0.709	-0.066	4.032	0.01	0.007	0	52	48.6	46	155	146	0	34	33
2015	7	22	22	44	8	0.702	-0.095	4.032	0.01	0.007	0	45.6	42.6	54.2	140	132	0	34	33
2015	7	22	22	54	8	0.689	-0.095	4.035	0.01	0.007	0	45.2	42.6	67.5	139	131	0	34	32
2015	7	22	23	4	8	0.715	-0.102	4.039	0.013	0.01	0	45.6	43	66.7	140	132	0	34	32
2015	7	22	23	14	8	0.709	-0.069	4.039	0.01	0.007	0	46	43	67.1	141	133	0	34	33
2015	7	22	23	24	8	0.719	-0.082	4.039	0.01	0.007	0	45.6	42.6	66.7	140	132	0	34	33
2015	7	22	23	34	8	0.696	-0.095	4.039	0.013	0.01	0	45.6	42.6	67.5	140	131	0	34	32
2015	7	22	23	44	8	0.689	-0.046	4.039	0.01	0.007	0	45.6	43	67.1	140	133	0	34	33
2015	7	22	23	54	8	0.689	-0.102	4.039	0.01	0.007	0	46	43	67.5	141	133	0	34	33
2015	7	23	0	4	8	0.689	-0.062	4.039	0.013	0.01	0	46	42.6	67.1	141	132	0	34	33
2015	7	23	0	14	8	0.686	-0.082	4.042	0.013	0.01	0	45.6	43	67.1	140	133	0	34	33
2015	7	23	0	24	8	0.702	-0.089	4.042	0.016	0.013	0	45.6	42.6	66.7	140	132	0	34	33
2015	7	23	0	34	8	0.702	-0.082	4.042	0.01	0.007	0	45.2	42.1	67.5	139	131	0	34	33
2015	7	23	0	44	8	0.705	-0.072	4.042	0.01	0.007	0	45.6	42.6	67.5	140	132	0	34	33
2015	7	23	0	54	8	0.709	-0.098	4.042	0.01	0.007	0	46	43	67.5	141	133	0	34	33
2015	7	23	1	4	8	0.692	-0.075	4.042	0.01	0.007	0	45.2	41.7	67.5	139	131	0	34	34
2015	7	23	1	14	8	0.709	-0.082	4.042	0.016	0.013	0	45.2	42.6	68.4	139	132	0	34	33
2015	7	23	1	24	8	0.653	-0.069	4.042	0.01	0.007	0	45.6	42.6	68.8	140	132	0	34	33
2015	7	23	1	34	8	0.748	-0.118	4.042	0.01	0.007	0	45.2	42.6	60.2	139	132	0	34	33
2015	7	23	1	44	8	0.666	-0.072	4.042	0.01	0.007	0	45.6	42.6	69.2	140	132	0	34	33
2015	7	23	1	54	8	0.702	-0.075	4.042	0.01	0.007	0	45.6	42.6	68.4	139	132	0	33	33
2015	7	23	2	4	8	0.686	-0.082	4.045	0.013	0.01	0	45.6	42.6	69.2	140	132	0	34	33
2015	7	23	2	14	8	0.715	-0.066	4.045	0.013	0.01	0	46	42.6	67.1	140	132	0	33	33
2015	7	23	2	24	8	0.689	-0.069	4.045	0.013	0.01	0	44.7	42.1	69.7	139	131	0	35	33
2015	7	23	2	34	8	0.715	-0.085	4.045	0.013	0.01	0	45.2	42.6	69.2	139	132	0	34	33
2015	7	23	2	44	8	0.722	-0.089	4.045	0.01	0.007	0	44.7	42.1	70.1	138	131	0	34	33
2015	7	23	2	54	8	0.709	-0.092	4.045	0.013	0.01	0	44.7	41.7	69.2	138	130	0	34	33
2015	7	23	3	4	8	0.682	-0.082	4.045	0.013	0.01	0	45.2	42.1	69.7	139	131	0	34	33
2015	7	23	3	14	8	0.725	-0.082	4.045	0.013	0.01	0	46	43	70.5	141	133	0	34	33
2015	7	23	3	24	8	0.735	-0.075	4.045	0.013	0.01	0	44.7	41.7	70.1	138	131	0	34	34
2015	7	23	3	34	8	0.719	-0.085	4.045	0.013	0.01	0	46	43	70.5	141	133	0	34	33
2015	7	23	3	44	8	0.682	-0.062	4.045	0.01	0.007	0	45.6	43	69.7	140	133	0	34	33
2015	7	23	3	54	8	0.679	-0.069	4.045	0.013	0.01	0	46	42.6	70.1	141	133	0	34	34
2015	7	23	4	4	8	0.725	-0.082	4.045	0.01	0.007	0	45.6	43	70.1	141	133	0	35	33
2015	7	23	4	14	8	0.699	-0.079	4.045	0.01	0.007	0	46	43.4	67.5	141	134	0	34	33
2015	7	23	4	24	8	0.699	-0.082	4.045	0.01	0.007	0	46	43.4	69.7	141	134	0	34	33
2015	7	23	4	34	8	0.719	-0.102	4.045	0.01	0.007	0	45.6	42.6	70.5	140	132	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	23	4	44	8	0.712	-0.082	4.045	0.01	0.007	0	45.2	42.6	71	139	132	0	34	33
2015	7	23	4	54	8	0.692	-0.092	4.045	0.013	0.01	0	46	43.4	70.5	141	134	0	34	33
2015	7	23	5	4	8	0.715	-0.056	4.045	0.013	0.01	0	46	43.4	70.1	141	134	0	34	33
2015	7	23	5	14	8	0.686	-0.075	4.045	0.01	0.007	0	45.6	43	71	141	133	0	35	33
2015	7	23	5	24	8	0.709	-0.075	4.049	0.01	0.007	0	46.4	43.4	70.1	142	134	0	34	33
2015	7	23	5	34	8	0.699	-0.066	4.045	0.01	0.007	0	46	42.6	71	140	132	0	33	33
2015	7	23	5	44	8	0.689	-0.089	4.049	0.01	0.007	0	45.6	42.6	70.5	140	132	0	34	33
2015	7	23	5	54	8	0.702	-0.075	4.045	0.01	0.007	0	45.6	42.6	70.1	140	132	0	34	33
2015	7	23	6	4	8	0.705	-0.082	4.045	0.01	0.007	0	45.2	42.6	71	140	132	0	35	33
2015	7	23	6	14	8	0.689	-0.072	4.049	0.01	0.007	0	44.7	42.1	70.5	138	131	0	34	33
2015	7	23	6	24	8	0.699	-0.056	4.049	0.01	0.007	0	45.2	42.6	71	139	132	0	34	33
2015	7	23	6	34	8	0.728	-0.095	4.049	0.01	0.007	0	44.7	42.1	70.5	138	131	0	34	33
2015	7	23	6	44	8	0.676	-0.095	4.049	0.013	0.01	0	45.2	42.6	70.5	139	132	0	34	33
2015	7	23	6	54	8	0.682	-0.062	4.045	0.013	0.01	0	45.2	42.6	71	139	132	0	34	33
2015	7	23	7	4	8	0.705	-0.089	4.049	0.01	0.007	0	45.6	42.6	71	140	132	0	34	33
2015	7	23	7	14	8	0.712	-0.115	4.049	0.01	0.007	0	45.2	42.1	71	139	131	0	34	33
2015	7	23	7	24	8	0.676	-0.102	4.049	0.01	0.007	0	46.4	43	69.2	141	133	0	33	33
2015	7	23	7	34	8	0.686	-0.092	4.049	0.01	0.007	0	44.7	42.1	60.2	139	132	0	35	34
2015	7	23	7	44	8	0.699	-0.095	4.049	0.01	0.007	0	44.7	42.6	59.3	139	132	0	35	33
2015	7	23	7	54	8	0.725	-0.102	4.049	0.01	0.007	0	45.2	42.6	63.2	139	132	0	34	33
2015	7	23	8	4	8	0.712	-0.082	4.049	0.01	0.007	0	44.3	41.7	60.6	137	130	0	34	33
2015	7	23	8	14	8	0.712	-0.092	4.049	0.01	0.007	0	44.7	42.1	60.6	138	131	0	34	33
2015	7	23	8	24	8	0.712	-0.102	4.049	0.01	0.007	0	44.3	41.7	58.5	137	130	0	34	33
2015	7	23	8	34	8	0.725	-0.135	4.049	0.016	0.016	0	43.9	41.7	54.2	136	130	0	34	33
2015	7	23	8	44	8	0.705	-0.082	4.049	0.013	0.01	0	44.3	41.7	52.9	137	130	0	34	33
2015	7	23	8	54	8	0.738	-0.115	4.049	0.016	0.013	0	44.3	42.1	67.5	137	130	0	34	32
2015	7	23	9	4	8	0.728	-0.115	4.049	0.01	0.007	0	44.7	42.6	53.8	138	131	0	34	32
2015	7	23	9	14	8	0.748	-0.089	4.049	0.013	0.01	0	44.3	41.7	63.6	137	130	0	34	33
2015	7	23	9	24	8	0.705	-0.135	4.049	0.016	0.013	0	44.7	42.1	50.7	138	131	0	34	33
2015	7	23	9	34	8	0.712	-0.118	4.049	0.013	0.01	0	44.3	41.7	60.6	137	130	0	34	33
2015	7	23	9	44	8	0.696	-0.089	4.049	0.016	0.013	0	44.3	41.7	54.2	138	130	0	35	33
2015	7	23	9	54	8	0.732	-0.144	4.045	0.01	0.007	0	44.3	41.7	58.9	137	130	0	34	33
2015	7	23	10	4	8	0.696	-0.102	4.049	0.01	0.007	0	44.3	42.1	55.9	138	131	0	35	33
2015	7	23	10	14	8	0.719	-0.098	4.045	0.01	0.007	0	44.3	41.3	50.3	137	129	0	34	33
2015	7	23	10	24	8	0.702	-0.108	4.049	0.01	0.007	0	44.7	41.7	53.3	138	130	0	34	33
2015	7	23	10	34	8	0.696	-0.105	4.045	0.01	0.007	0	43.9	41.3	57.2	136	129	0	34	33
2015	7	23	10	44	8	0.719	-0.148	4.045	0.01	0.007	0	43.9	41.7	59.8	136	129	0	34	32
2015	7	23	10	54	8	0.712	-0.128	4.045	0.01	0.007	0	43.9	40.9	54.2	136	128	0	34	33
2015	7	23	11	4	8	0.702	-0.108	4.045	0.01	0.007	0	43.4	41.3	52.9	136	129	0	35	33
2015	7	23	11	14	8	0.696	-0.148	4.045	0.01	0.007	0	43.9	41.3	53.3	136	129	0	34	33
2015	7	23	11	24	8	0.715	-0.121	4.045	0.01	0.007	0	43.4	40.9	63.2	135	128	0	34	33
2015	7	23	11	34	8	0.679	-0.154	4.045	0.01	0.007	0	43.4	41.3	64.1	135	128	0	34	32
2015	7	23	11	44	8	0.702	-0.141	4.045	0.01	0.007	0	43.9	41.3	58.5	136	129	0	34	33
2015	7	23	11	54	8	0.722	-0.089	4.045	0.01	0.007	0	43.9	41.7	53.8	136	130	0	34	33
2015	7	23	12	4	8	0.728	-0.135	4.045	0.013	0.01	0	43.4	41.7	57.6	136	130	0	35	33
2015	7	23	12	14	8	0.696	-0.148	4.042	0.01	0.007	0	43.9	41.3	51.6	136	129	0	34	33
2015	7	23	12	24	8	0.689	-0.177	4.042	0.013	0.01	0	43.4	40.9	49	135	128	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	23	12	34	8	0.696	-0.144	4.042	0.01	0.007	0	43.9	40.9	55.9	136	128	0	34	33
2015	7	23	12	44	8	0.728	-0.197	4.039	0.013	0.01	0	43.9	40.9	50.3	135	128	0	33	33
2015	7	23	12	54	8	0.702	-0.135	4.042	0.013	0.01	0	43	40.9	53.8	135	128	0	35	33
2015	7	23	13	4	8	0.699	-0.118	4.042	0.013	0.01	0	43.9	40.9	50.7	135	128	0	33	33
2015	7	23	13	14	8	0.679	-0.131	4.039	0.01	0.007	0	43.4	40.9	49.5	135	128	0	34	33
2015	7	23	13	24	8	0.705	-0.121	4.039	0.013	0.01	0	44.3	41.3	49.9	137	129	0	34	33
2015	7	23	13	34	8	0.679	-0.154	4.039	0.013	0.01	0	43.4	40.9	49	135	128	0	34	33
2015	7	23	13	44	8	0.679	-0.157	4.039	0.01	0.007	0	43.4	41.3	49.5	135	128	0	34	32
2015	7	23	13	54	8	0.705	-0.082	4.039	0.01	0.007	0	43.4	41.3	49.5	136	129	0	35	33
2015	7	23	14	4	8	0.722	-0.112	4.035	0.01	0.007	0	44.3	41.7	48.2	137	130	0	34	33
2015	7	23	14	14	8	0.679	-0.138	4.035	0.013	0.01	0	43.9	41.3	48.6	136	129	0	34	33
2015	7	23	14	24	8	0.699	-0.154	4.035	0.016	0.013	0	44.7	41.3	49	137	130	0	33	34
2015	7	23	14	34	8	0.719	-0.131	4.035	0.013	0.01	0	44.3	42.6	48.2	137	131	0	34	32
2015	7	23	14	44	8	0.682	-0.118	4.032	0.01	0.007	0	44.7	42.1	50.7	138	131	0	34	33
2015	7	23	14	54	8	0.663	-0.121	4.035	0.013	0.01	0	44.3	41.7	49	138	131	0	35	34
2015	7	23	15	4	8	0.702	-0.102	4.032	0.013	0.01	0	44.7	43	49	138	132	0	34	32
2015	7	23	15	14	8	0.679	-0.154	4.032	0.01	0.007	0	44.3	42.1	47.7	137	130	0	34	32
2015	7	23	15	24	8	0.699	-0.135	4.029	0.016	0.013	0	44.3	42.1	47.7	138	131	0	35	33
2015	7	23	15	34	8	0.65	-0.144	4.032	0.013	0.01	0	44.7	42.1	49	138	131	0	34	33
2015	7	23	15	44	8	0.696	-0.138	4.032	0.016	0.013	0	44.7	42.1	47.3	138	131	0	34	33
2015	7	23	15	54	8	0.692	-0.102	4.029	0.01	0.007	0	45.6	42.6	47.7	139	132	0	33	33
2015	7	23	16	4	8	0.692	-0.148	4.032	0.01	0.007	0	45.2	42.1	48.2	139	131	0	34	33
2015	7	23	16	14	8	0.676	-0.135	4.032	0.01	0.007	0	44.7	42.1	48.6	138	131	0	34	33
2015	7	23	16	24	8	0.722	-0.105	4.029	0.016	0.013	0	44.7	42.6	48.6	138	131	0	34	32
2015	7	23	16	34	8	0.689	-0.112	4.029	0.01	0.007	0	44.7	41.7	47.3	138	130	0	34	33
2015	7	23	16	44	8	0.699	-0.144	4.029	0.01	0.007	0	44.3	42.1	47.7	137	130	0	34	32
2015	7	23	16	54	8	0.673	-0.112	4.029	0.013	0.01	0	44.3	42.1	48.2	138	131	0	35	33
2015	7	23	17	4	8	0.732	-0.125	4.029	0.013	0.01	0	44.3	41.7	47.7	137	130	0	34	33
2015	7	23	17	14	8	0.686	-0.135	4.029	0.01	0.007	0	44.7	42.1	45.6	138	131	0	34	33
2015	7	23	17	24	8	0.722	-0.144	4.026	0.01	0.007	0	43.9	41.3	49.5	136	129	0	34	33
2015	7	23	17	34	8	0.689	-0.102	4.026	0.013	0.01	0	43.9	41.3	50.7	136	129	0	34	33
2015	7	23	17	44	8	0.699	-0.102	4.026	0.013	0.01	0	44.7	41.7	51.2	137	130	0	33	33
2015	7	23	17	54	8	0.725	-0.108	4.026	0.01	0.007	0	44.3	42.1	49.5	138	131	0	35	33
2015	7	23	18	4	8	0.682	-0.105	4.029	0.01	0.007	0	45.2	42.1	50.7	138	131	0	33	33
2015	7	23	18	14	8	0.692	-0.125	4.026	0.013	0.01	0	44.3	42.6	49	137	131	0	34	32
2015	7	23	18	24	8	0.705	-0.082	4.026	0.013	0.01	0	44.7	42.6	51.2	138	131	0	34	32
2015	7	23	18	34	8	0.709	-0.075	4.026	0.016	0.013	0	43.9	41.3	47.7	136	129	0	34	33
2015	7	23	18	44	8	0.689	-0.105	4.026	0.013	0.01	0	44.3	41.3	48.6	137	130	0	34	34
2015	7	23	18	54	8	0.669	-0.098	4.026	0.01	0.007	0	44.3	41.7	51.6	137	130	0	34	33
2015	7	23	19	4	8	0.692	-0.082	4.026	0.01	0.007	0	44.3	41.7	50.7	137	130	0	34	33
2015	7	23	19	14	8	0.699	-0.095	4.026	0.013	0.01	0	44.7	41.7	49.5	138	130	0	34	33
2015	7	23	19	24	8	0.715	-0.075	4.026	0.01	0.007	0	44.3	42.1	48.6	137	130	0	34	32
2015	7	23	19	34	8	0.702	-0.082	4.026	0.013	0.01	0	44.3	42.1	49	138	131	0	35	33
2015	7	23	19	44	8	0.699	-0.066	4.026	0.01	0.007	0	45.6	42.6	51.6	139	131	0	33	32
2015	7	23	19	54	8	0.715	-0.092	4.026	0.016	0.013	0	43.9	41.7	52.9	137	130	0	35	33
2015	7	23	20	4	8	0.735	-0.108	4.022	0.016	0.013	0	44.7	41.7	50.3	137	130	0	33	33
2015	7	23	20	14	8	0.679	-0.108	4.022	0.01	0.007	0	45.6	43	61.9	140	133	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	23	20	24	8	0.699	-0.046	4.029	0.013	0.01	0	45.6	43.4	49.5	140	133	0	34	32
2015	7	23	20	34	8	0.692	-0.082	4.029	0.01	0.007	0	46	43.4	50.3	141	134	0	34	33
2015	7	23	20	44	8	0.709	-0.059	4.026	0.01	0.007	0	46.4	43.9	47.3	142	135	0	34	33
2015	7	23	20	54	8	0.715	-0.082	4.029	0.016	0.013	0	45.6	43	49.9	140	132	0	34	32
2015	7	23	21	4	8	0.686	-0.066	4.029	0.01	0.007	0	46	43.9	49.5	141	134	0	34	32
2015	7	23	21	14	8	0.686	-0.069	4.029	0.01	0.007	0	46.4	43	49	141	133	0	33	33
2015	7	23	21	24	8	0.692	-0.052	4.029	0.016	0.013	0	46	43.4	49.9	141	134	0	34	33
2015	7	23	21	34	8	0.705	-0.056	4.029	0.013	0.01	0	45.2	42.6	48.2	140	132	0	35	33
2015	7	23	21	44	8	0.699	-0.085	4.029	0.01	0.007	0	46	42.6	47.7	141	132	0	34	33
2015	7	23	21	54	8	0.741	-0.052	4.029	0.01	0.007	0	46	43.4	52	141	133	0	34	32
2015	7	23	22	4	8	0.719	-0.066	4.029	0.01	0.007	0	46	43.4	50.7	141	134	0	34	33
2015	7	23	22	14	8	0.682	-0.085	4.026	0.01	0.007	0	45.6	43	53.8	140	132	0	34	32
2015	7	23	22	24	8	0.715	-0.095	4.026	0.016	0.013	0	45.2	42.1	61.1	139	131	0	34	33
2015	7	23	22	34	8	0.692	-0.069	4.026	0.013	0.01	0	45.6	42.6	59.3	140	132	0	34	33
2015	7	23	22	44	8	0.702	-0.115	4.026	0.01	0.007	0	45.2	42.1	67.5	139	131	0	34	33
2015	7	23	22	54	8	0.676	-0.085	4.026	0.013	0.01	0	45.6	42.6	66.2	140	132	0	34	33
2015	7	23	23	4	8	0.728	-0.095	4.026	0.01	0.007	0	45.6	42.6	66.7	140	132	0	34	33
2015	7	23	23	14	8	0.702	-0.089	4.026	0.016	0.013	0	46	42.6	67.1	141	132	0	34	33
2015	7	23	23	24	8	0.696	-0.062	4.029	0.013	0.01	0	45.6	42.6	65.8	140	132	0	34	33
2015	7	23	23	34	8	0.699	-0.085	4.026	0.016	0.013	0	45.6	43	66.7	140	132	0	34	32
2015	7	23	23	44	8	0.682	-0.089	4.029	0.01	0.007	0	45.6	42.6	64.5	140	132	0	34	33
2015	7	23	23	54	8	0.732	-0.095	4.029	0.013	0.01	0	45.2	42.1	57.6	138	131	0	33	33
2015	7	24	0	4	8	0.719	-0.082	4.029	0.01	0.007	0	44.7	42.1	65.8	138	131	0	34	33
2015	7	24	0	14	8	0.715	-0.085	4.032	0.01	0.007	0	45.2	42.1	64.9	139	131	0	34	33
2015	7	24	0	24	8	0.692	-0.069	4.029	0.01	0.007	0	45.2	42.6	66.2	139	132	0	34	33
2015	7	24	0	34	8	0.722	-0.105	4.032	0.013	0.01	0	45.2	42.6	65.8	139	131	0	34	32
2015	7	24	0	44	8	0.699	-0.075	4.032	0.01	0.007	0	45.6	42.6	65.8	140	132	0	34	33
2015	7	24	0	54	8	0.722	-0.095	4.035	0.016	0.013	0	45.2	42.1	63.6	139	131	0	34	33
2015	7	24	1	4	8	0.725	-0.102	4.035	0.01	0.007	0	45.2	43	67.5	140	133	0	35	33
2015	7	24	1	14	8	0.702	-0.085	4.035	0.01	0.007	0	46.4	42.6	66.7	141	133	0	33	34
2015	7	24	1	24	8	0.692	-0.069	4.039	0.01	0.007	0	45.6	42.6	66.2	140	132	0	34	33
2015	7	24	1	34	8	0.738	-0.102	4.039	0.01	0.007	0	45.2	43	67.9	140	132	0	35	32
2015	7	24	1	44	8	0.715	-0.079	4.039	0.01	0.007	0	45.6	42.6	66.7	140	132	0	34	33
2015	7	24	1	54	8	0.705	-0.072	4.039	0.016	0.013	0	45.2	42.6	67.1	139	132	0	34	33
2015	7	24	2	4	8	0.712	-0.089	4.039	0.01	0.007	0	45.2	42.6	67.1	139	132	0	34	33
2015	7	24	2	14	8	0.715	-0.115	4.039	0.01	0.007	0	45.6	43	66.7	140	132	0	34	32
2015	7	24	2	24	8	0.709	-0.098	4.039	0.013	0.01	0	45.6	43	67.9	141	133	0	35	33
2015	7	24	2	34	8	0.732	-0.102	4.039	0.013	0.01	0	45.2	42.1	67.5	139	131	0	34	33
2015	7	24	2	44	8	0.659	-0.092	4.039	0.01	0.007	0	45.6	42.6	67.9	140	132	0	34	33
2015	7	24	2	54	8	0.679	-0.069	4.042	0.016	0.016	0	46	43	67.9	141	133	0	34	33
2015	7	24	3	4	8	0.712	-0.082	4.039	0.01	0.007	0	45.6	42.6	68.4	140	132	0	34	33
2015	7	24	3	14	8	0.709	-0.108	4.042	0.013	0.01	0	46	42.6	67.9	140	132	0	33	33
2015	7	24	3	24	8	0.732	-0.069	4.042	0.01	0.007	0	46	43	68.8	141	133	0	34	33
2015	7	24	3	34	8	0.679	-0.072	4.042	0.016	0.013	0	45.6	42.6	68.8	140	132	0	34	33
2015	7	24	3	44	8	0.696	-0.072	4.042	0.013	0.01	0	45.6	42.1	68.4	140	131	0	34	33
2015	7	24	3	54	8	0.699	-0.046	4.042	0.01	0.007	0	45.6	42.6	69.7	140	132	0	34	33
2015	7	24	4	4	8	0.755	-0.089	4.042	0.01	0.007	0	45.2	42.6	68.8	140	132	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	24	4	14	8	0.732	-0.079	4.042	0.01	0.007	0	46	43	68.4	140	133	0	33	33
2015	7	24	4	24	8	0.696	-0.072	4.042	0.01	0.007	0	46	43	69.7	141	133	0	34	33
2015	7	24	4	34	8	0.699	-0.069	4.042	0.013	0.01	0	46.4	42.6	69.7	142	133	0	34	34
2015	7	24	4	44	8	0.699	-0.085	4.042	0.016	0.013	0	45.6	43	69.2	140	132	0	34	32
2015	7	24	4	54	8	0.696	-0.056	4.042	0.01	0.007	0	45.6	42.6	69.2	140	132	0	34	33
2015	7	24	5	4	8	0.699	-0.069	4.042	0.01	0.007	0	46	43	70.1	141	133	0	34	33
2015	7	24	5	14	8	0.686	-0.085	4.042	0.016	0.013	0	45.2	42.6	70.1	139	132	0	34	33
2015	7	24	5	24	8	0.686	-0.082	4.042	0.013	0.01	0	46	43	69.7	141	133	0	34	33
2015	7	24	5	34	8	0.696	-0.092	4.042	0.01	0.007	0	45.6	42.6	70.1	140	132	0	34	33
2015	7	24	5	44	8	0.709	-0.092	4.042	0.013	0.01	0	45.2	42.6	70.5	140	132	0	35	33
2015	7	24	5	54	8	0.715	-0.102	4.042	0.016	0.013	0	45.2	42.6	69.7	139	131	0	34	32
2015	7	24	6	4	8	0.673	-0.062	4.042	0.01	0.007	0	44.7	42.1	70.5	139	131	0	35	33
2015	7	24	6	14	8	0.689	-0.056	4.042	0.013	0.01	0	45.6	42.1	71	140	132	0	34	34
2015	7	24	6	24	8	0.679	-0.092	4.045	0.01	0.007	0	45.2	41.7	68.8	138	130	0	33	33
2015	7	24	6	34	8	0.702	-0.075	4.042	0.013	0.01	0	44.7	41.3	71	138	130	0	34	34
2015	7	24	6	44	8	0.719	-0.092	4.042	0.013	0.01	0	45.2	42.1	71	139	131	0	34	33
2015	7	24	6	54	8	0.722	-0.082	4.045	0.01	0.007	0	45.2	41.7	71.8	139	130	0	34	33
2015	7	24	7	4	8	0.712	-0.072	4.045	0.01	0.007	0	44.7	42.1	71.4	138	131	0	34	33
2015	7	24	7	14	8	0.728	-0.082	4.042	0.01	0.007	0	44.7	41.3	71.4	138	130	0	34	34
2015	7	24	7	24	8	0.702	-0.102	4.042	0.01	0.007	0	45.2	42.6	71.4	139	132	0	34	33
2015	7	24	7	34	8	0.676	-0.085	4.045	0.01	0.007	0	44.7	42.1	71.4	138	131	0	34	33
2015	7	24	7	44	8	0.692	-0.085	4.042	0.013	0.01	0	44.7	41.7	72.2	138	130	0	34	33
2015	7	24	7	54	8	0.745	-0.095	4.045	0.01	0.007	0	45.2	42.6	71.4	139	131	0	34	32
2015	7	24	8	4	8	0.692	-0.052	4.045	0.01	0.007	0	45.2	42.1	71.4	139	131	0	34	33
2015	7	24	8	14	8	0.692	-0.075	4.045	0.01	0.007	0	45.6	42.1	69.2	140	132	0	34	34
2015	7	24	8	24	8	0.676	-0.079	4.045	0.01	0.007	0	44.7	41.7	71.8	138	130	0	34	33
2015	7	24	8	34	8	0.715	-0.112	4.042	0.01	0.007	0	44.7	41.7	71	138	130	0	34	33
2015	7	24	8	44	8	0.702	-0.069	4.045	0.016	0.013	0	44.7	42.1	71	138	131	0	34	33
2015	7	24	8	54	8	0.722	-0.095	4.042	0.01	0.007	0	44.3	41.3	70.5	137	130	0	34	34
2015	7	24	9	4	8	0.725	-0.115	4.042	0.01	0.007	0	44.3	41.3	71.4	137	129	0	34	33
2015	7	24	9	14	8	0.722	-0.105	4.042	0.013	0.01	0	44.3	41.7	68.4	137	130	0	34	33
2015	7	24	9	24	8	0.692	-0.128	4.042	0.01	0.007	0	44.7	41.7	66.2	138	130	0	34	33
2015	7	24	9	34	8	0.728	-0.089	4.042	0.013	0.01	0	43.9	41.7	60.2	137	130	0	35	33
2015	7	24	9	44	8	0.702	-0.125	4.042	0.01	0.007	0	44.3	41.3	68.4	137	129	0	34	33
2015	7	24	9	54	8	0.699	-0.138	4.042	0.01	0.007	0	43.9	41.7	70.5	137	130	0	35	33
2015	7	24	10	4	8	0.712	-0.135	4.042	0.01	0.007	0	44.3	41.3	67.1	137	130	0	34	34
2015	7	24	10	14	8	0.686	-0.102	4.042	0.01	0.007	0	45.2	42.1	59.3	139	131	0	34	33
2015	7	24	10	24	8	0.722	-0.144	4.042	0.01	0.007	0	44.3	41.3	70.1	137	129	0	34	33
2015	7	24	10	34	8	0.709	-0.085	4.042	0.013	0.01	0	44.7	41.7	68.4	138	130	0	34	33
2015	7	24	10	44	8	0.725	-0.144	4.042	0.01	0.007	0	44.7	41.7	68.8	138	130	0	34	33
2015	7	24	10	54	8	0.715	-0.105	4.039	0.01	0.007	0	45.2	42.6	60.2	139	132	0	34	33
2015	7	24	11	4	8	0.728	-0.102	4.039	0.013	0.01	0	45.2	42.1	69.2	139	131	0	34	33
2015	7	24	11	14	8	0.712	-0.105	4.039	0.013	0.01	0	45.2	42.6	56.8	139	132	0	34	33
2015	7	24	11	24	8	0.709	-0.102	4.039	0.01	0.007	0	44.3	41.7	64.9	137	130	0	34	33
2015	7	24	11	34	8	0.715	-0.079	4.039	0.01	0.007	0	45.2	42.6	67.5	139	132	0	34	33
2015	7	24	11	44	8	0.699	-0.092	4.039	0.01	0.007	0	44.7	41.7	64.1	138	130	0	34	33
2015	7	24	11	54	8	0.719	-0.131	4.039	0.01	0.007	0	44.3	41.7	56.3	138	130	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	24	12	4	8	0.728	-0.138	4.035	0.01	0.007	0	44.3	41.3	63.6	137	129	0	34	33
2015	7	24	12	14	8	0.696	-0.115	4.035	0.01	0.007	0	44.7	42.1	52.5	139	131	0	35	33
2015	7	24	12	24	8	0.696	-0.135	4.035	0.016	0.013	0	44.3	41.3	67.5	137	129	0	34	33
2015	7	24	12	34	8	0.725	-0.108	4.035	0.01	0.007	0	44.7	42.6	65.4	138	131	0	34	32
2015	7	24	12	44	8	0.728	-0.187	4.029	0.01	0.007	0	44.3	41.3	55	137	129	0	34	33
2015	7	24	12	54	8	0.741	-0.135	4.029	0.01	0.007	0	43.9	41.3	62.8	137	129	0	35	33
2015	7	24	13	4	8	0.722	-0.118	4.029	0.01	0.007	0	44.7	41.7	61.9	138	130	0	34	33
2015	7	24	13	14	8	0.699	-0.138	4.029	0.01	0.007	0	44.3	41.3	55.9	137	129	0	34	33
2015	7	24	13	24	8	0.705	-0.105	4.026	0.01	0.007	0	45.2	42.1	62.8	139	131	0	34	33
2015	7	24	13	34	8	0.715	-0.102	4.026	0.013	0.01	0	43.9	41.3	58.9	136	129	0	34	33
2015	7	24	13	44	8	0.673	-0.135	4.026	0.013	0.01	0	43.9	40.9	52.9	136	128	0	34	33
2015	7	24	13	54	8	0.699	-0.115	4.026	0.01	0.007	0	44.3	41.3	52	137	129	0	34	33
2015	7	24	14	4	8	0.696	-0.151	4.022	0.01	0.007	0	43.9	40.9	64.5	136	128	0	34	33
2015	7	24	14	14	8	0.709	-0.131	4.022	0.01	0.007	0	43.9	40.9	62.4	136	128	0	34	33
2015	7	24	14	24	8	0.705	-0.121	4.026	0.016	0.013	0	44.7	42.6	53.8	138	131	0	34	32
2015	7	24	14	34	8	0.699	-0.125	4.022	0.016	0.013	0	44.7	41.7	50.7	138	130	0	34	33
2015	7	24	14	44	8	0.692	-0.171	4.019	0.013	0.01	0	44.3	41.3	65.4	137	129	0	34	33
2015	7	24	14	54	8	0.702	-0.141	4.019	0.01	0.007	0	44.3	41.3	60.6	137	129	0	34	33
2015	7	24	15	4	8	0.699	-0.131	4.019	0.013	0.01	0	44.3	41.7	53.3	137	129	0	34	32
2015	7	24	15	14	8	0.699	-0.144	4.019	0.01	0.007	0	44.3	41.3	55	137	130	0	34	34
2015	7	24	15	24	8	0.715	-0.105	4.019	0.01	0.007	0	45.2	41.7	53.8	138	130	0	33	33
2015	7	24	15	34	8	0.699	-0.141	4.019	0.013	0.01	0	44.7	41.7	55.5	138	130	0	34	33
2015	7	24	15	44	8	0.705	-0.128	4.019	0.01	0.007	0	44.3	41.7	53.3	137	130	0	34	33
2015	7	24	15	54	8	0.712	-0.102	4.019	0.01	0.007	0	44.3	41.7	54.2	138	130	0	35	33
2015	7	24	16	4	8	0.702	-0.148	4.016	0.01	0.007	0	44.7	41.7	55.5	138	130	0	34	33
2015	7	24	16	14	8	0.722	-0.118	4.016	0.01	0.007	0	44.3	41.7	61.5	137	130	0	34	33
2015	7	24	16	24	8	0.728	-0.069	4.016	0.01	0.007	0	44.7	41.7	56.8	137	130	0	33	33
2015	7	24	16	34	8	0.728	-0.121	4.016	0.01	0.007	0	44.3	42.1	70.5	137	130	0	34	32
2015	7	24	16	44	8	0.722	-0.138	4.016	0.01	0.007	0	44.3	41.7	57.6	137	130	0	34	33
2015	7	24	16	54	8	0.728	-0.128	4.016	0.01	0.007	0	44.3	42.1	64.5	137	130	0	34	32
2015	7	24	17	4	8	0.732	-0.108	4.016	0.01	0.007	0	45.2	42.1	67.5	139	131	0	34	33
2015	7	24	17	14	8	0.699	-0.118	4.016	0.01	0.007	0	44.7	42.1	53.3	138	130	0	34	32
2015	7	24	17	24	8	0.732	-0.102	4.012	0.016	0.013	0	52.9	49.9	35.3	157	150	0	34	34
2015	7	24	17	34	8	0.719	-0.102	4.016	0.01	0.007	0	47.3	43.4	43.9	144	134	0	34	33
2015	7	24	17	44	8	0.702	-0.098	4.012	0.01	0.007	0	54.2	51.6	35.3	160	152	0	34	32
2015	7	24	17	54	8	0.732	-0.121	4.012	0.013	0.01	0	52.9	49.9	43.9	157	149	0	34	33
2015	7	24	18	4	8	0.745	-0.115	4.012	0.016	0.013	0	50.3	45.2	38.7	151	137	0	34	32
2015	7	24	18	14	8	0.761	-0.118	4.016	0.01	0.007	0	45.6	42.6	46.9	141	132	0	35	33
2015	7	24	18	24	8	0.745	-0.102	4.016	0.01	0.007	0	46.4	42.6	44.7	142	132	0	34	33
2015	7	24	18	34	8	0.705	-0.121	4.016	0.016	0.013	0	43.9	41.3	49.9	137	129	0	35	33
2015	7	24	18	44	8	0.715	-0.112	4.016	0.013	0.01	0	43.9	41.7	49.9	137	130	0	35	33
2015	7	24	18	54	8	0.719	-0.085	4.016	0.01	0.007	0	44.7	41.7	54.2	137	130	0	33	33
2015	7	24	19	4	8	0.696	-0.118	4.016	0.01	0.007	0	44.3	41.7	64.5	137	130	0	34	33
2015	7	24	19	14	8	0.725	-0.118	4.016	0.01	0.007	0	44.3	41.7	56.8	137	130	0	34	33
2015	7	24	19	24	8	0.715	-0.072	4.016	0.01	0.007	0	45.2	42.1	59.8	139	131	0	34	33
2015	7	24	19	34	8	0.663	-0.082	4.016	0.01	0.007	0	45.6	43	61.9	140	133	0	34	33
2015	7	24	19	44	8	0.709	-0.108	4.016	0.01	0.007	0	45.2	42.6	68.4	139	131	0	34	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	24	19	54	8	0.686	-0.085	4.016	0.013	0.01	0	45.6	43	69.2	140	132	0	34	32
2015	7	24	20	4	8	0.725	-0.059	4.016	0.01	0.007	0	45.2	43	69.2	140	132	0	35	32
2015	7	24	20	14	8	0.725	-0.075	4.016	0.01	0.007	0	46.4	43.4	69.7	141	134	0	33	33
2015	7	24	20	24	8	0.682	-0.059	4.016	0.01	0.007	0	45.6	43.4	69.2	141	134	0	35	33
2015	7	24	20	34	8	0.679	-0.085	4.016	0.01	0.007	0	46.4	44.3	67.9	142	135	0	34	32
2015	7	24	20	44	8	0.715	-0.079	4.016	0.01	0.007	0	46.9	44.3	67.9	143	136	0	34	33
2015	7	24	20	54	8	0.705	-0.079	4.016	0.01	0.007	0	46.9	44.3	67.9	143	136	0	34	33
2015	7	24	21	4	8	0.725	-0.082	4.016	0.01	0.007	0	46	43.9	68.8	142	135	0	35	33
2015	7	24	21	14	8	0.699	-0.098	4.016	0.01	0.007	0	46	43	65.8	141	134	0	34	34
2015	7	24	21	24	8	0.666	-0.069	4.016	0.01	0.007	0	46.4	43.9	69.2	142	135	0	34	33
2015	7	24	21	34	8	0.725	-0.102	4.016	0.013	0.01	0	46	43.4	69.2	141	134	0	34	33
2015	7	24	21	44	8	0.689	-0.089	4.016	0.01	0.007	0	46.4	43.9	69.2	142	135	0	34	33
2015	7	24	21	54	8	0.702	-0.089	4.016	0.013	0.01	0	46	43	69.7	141	133	0	34	33
2015	7	24	22	4	8	0.666	-0.118	4.016	0.01	0.007	0	46	43.4	69.2	141	134	0	34	33
2015	7	24	22	14	8	0.679	-0.079	4.016	0.016	0.013	0	46	43.4	69.2	141	134	0	34	33
2015	7	24	22	24	8	0.696	-0.072	4.016	0.01	0.007	0	46	43.4	69.7	141	133	0	34	32
2015	7	24	22	34	8	0.682	-0.079	4.019	0.013	0.01	0	45.6	43	69.2	140	133	0	34	33
2015	7	24	22	44	8	0.686	-0.108	4.019	0.01	0.007	0	45.6	43	69.2	140	133	0	34	33
2015	7	24	22	54	8	0.715	-0.085	4.019	0.01	0.007	0	45.6	43	69.2	140	133	0	34	33
2015	7	24	23	4	8	0.676	-0.069	4.019	0.01	0.007	0	46.4	43.4	68.8	142	134	0	34	33
2015	7	24	23	14	8	0.656	-0.056	4.019	0.016	0.013	0	46	43.4	69.7	141	134	0	34	33
2015	7	24	23	24	8	0.692	-0.066	4.019	0.013	0.01	0	45.6	43.4	68.4	140	133	0	34	32
2015	7	24	23	34	8	0.663	-0.069	4.019	0.01	0.007	0	46.4	43.9	70.1	142	135	0	34	33
2015	7	24	23	44	8	0.666	-0.089	4.019	0.01	0.007	0	46.4	43.4	69.7	141	134	0	33	33
2015	7	24	23	54	8	0.689	-0.112	4.019	0.01	0.007	0	45.2	42.6	69.7	140	132	0	35	33
2015	7	25	0	4	8	0.702	-0.069	4.019	0.01	0.007	0	46	43	68.4	141	133	0	34	33
2015	7	25	0	14	8	0.692	-0.108	4.019	0.013	0.01	0	45.6	42.6	68.4	140	132	0	34	33
2015	7	25	0	24	8	0.712	-0.072	4.019	0.013	0.01	0	46	43	60.6	141	133	0	34	33
2015	7	25	0	34	8	0.686	-0.108	4.019	0.01	0.007	0	46	43	67.1	141	133	0	34	33
2015	7	25	0	44	8	0.728	-0.079	4.019	0.013	0.01	0	46	43.4	68.4	141	134	0	34	33
2015	7	25	0	54	8	0.682	-0.052	4.019	0.01	0.007	0	45.6	43	69.2	140	133	0	34	33
2015	7	25	1	4	8	0.702	-0.075	4.019	0.013	0.01	0	45.6	42.6	69.7	140	132	0	34	33
2015	7	25	1	14	8	0.686	-0.066	4.019	0.013	0.01	0	46.4	43	67.9	141	133	0	33	33
2015	7	25	1	24	8	0.735	-0.082	4.019	0.01	0.007	0	45.6	42.1	68.8	140	132	0	34	34
2015	7	25	1	34	8	0.686	-0.059	4.019	0.016	0.013	0	46	43.9	68.8	141	134	0	34	32
2015	7	25	1	44	8	0.663	-0.039	4.019	0.013	0.01	0	46	43	68.8	141	133	0	34	33
2015	7	25	1	54	8	0.686	-0.075	4.019	0.01	0.007	0	45.2	43.4	69.2	140	133	0	35	32
2015	7	25	2	4	8	0.719	-0.098	4.019	0.016	0.013	0	45.2	42.6	68.8	139	132	0	34	33
2015	7	25	2	14	8	0.715	-0.082	4.019	0.01	0.007	0	45.6	42.6	67.1	140	132	0	34	33
2015	7	25	2	24	8	0.676	-0.066	4.019	0.013	0.01	0	45.6	43.4	68.4	140	133	0	34	32
2015	7	25	2	34	8	0.738	-0.095	4.019	0.016	0.013	0	45.2	43	67.9	139	132	0	34	32
2015	7	25	2	44	8	0.715	-0.075	4.019	0.01	0.007	0	46	43	68.4	140	133	0	33	33
2015	7	25	2	54	8	0.699	-0.098	4.019	0.01	0.007	0	45.6	43	67.9	140	132	0	34	32
2015	7	25	3	4	8	0.699	-0.079	4.019	0.01	0.007	0	46	43	67.5	141	133	0	34	33
2015	7	25	3	14	8	0.745	-0.095	4.019	0.01	0.007	0	45.6	42.6	67.9	140	132	0	34	33
2015	7	25	3	24	8	0.682	-0.082	4.019	0.013	0.01	0	45.6	42.6	66.7	140	133	0	34	34
2015	7	25	3	34	8	0.705	-0.069	4.019	0.013	0.01	0	46	43.4	67.1	141	134	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	25	3	44	8	0.712	-0.102	4.022	0.016	0.013	0	45.2	43.4	68.4	140	133	0	35	32
2015	7	25	3	54	8	0.686	-0.069	4.022	0.013	0.01	0	46.4	43.9	67.9	142	134	0	34	32
2015	7	25	4	4	8	0.679	-0.069	4.022	0.01	0.007	0	46	43	67.9	141	133	0	34	33
2015	7	25	4	14	8	0.679	-0.079	4.022	0.013	0.01	0	45.6	43.4	68.4	140	133	0	34	32
2015	7	25	4	24	8	0.689	-0.079	4.022	0.01	0.007	0	46.9	44.3	65.4	143	135	0	34	32
2015	7	25	4	34	8	0.702	-0.075	4.022	0.01	0.007	0	46.4	43.9	66.7	142	134	0	34	32
2015	7	25	4	44	8	0.692	-0.059	4.022	0.016	0.013	0	46.4	43.4	67.5	142	134	0	34	33
2015	7	25	4	54	8	0.702	-0.102	4.022	0.01	0.007	0	45.6	43	67.1	140	133	0	34	33
2015	7	25	5	4	8	0.715	-0.079	4.022	0.01	0.007	0	46.4	43.4	67.5	142	134	0	34	33
2015	7	25	5	14	8	0.702	-0.075	4.022	0.013	0.01	0	45.6	43	66.7	140	133	0	34	33
2015	7	25	5	24	8	0.712	-0.125	4.022	0.013	0.01	0	46	43	66.7	141	133	0	34	33
2015	7	25	5	34	8	0.732	-0.112	4.022	0.013	0.01	0	45.6	42.6	66.2	140	132	0	34	33
2015	7	25	5	44	8	0.679	-0.062	4.022	0.01	0.007	0	46	43	66.7	141	133	0	34	33
2015	7	25	5	54	8	0.692	-0.085	4.022	0.01	0.007	0	45.6	43	66.7	140	133	0	34	33
2015	7	25	6	4	8	0.682	-0.095	4.022	0.013	0.01	0	45.6	42.6	67.1	140	132	0	34	33
2015	7	25	6	14	8	0.725	-0.098	4.022	0.013	0.01	0	45.6	42.6	67.1	140	132	0	34	33
2015	7	25	6	24	8	0.686	-0.069	4.029	0.01	0.007	0	45.6	42.6	66.7	140	132	0	34	33
2015	7	25	6	34	8	0.682	-0.052	4.026	0.01	0.007	0	45.6	43	66.7	141	133	0	35	33
2015	7	25	6	44	8	0.725	-0.095	4.026	0.01	0.007	0	45.6	42.6	65.8	140	132	0	34	33
2015	7	25	6	54	8	0.712	-0.085	4.029	0.013	0.01	0	45.2	42.1	67.1	139	131	0	34	33
2015	7	25	7	4	8	0.676	-0.089	4.029	0.016	0.013	0	45.6	42.6	67.1	140	132	0	34	33
2015	7	25	7	14	8	0.705	-0.095	4.029	0.013	0.01	0	45.6	42.6	66.2	140	132	0	34	33
2015	7	25	7	24	8	0.692	-0.033	4.029	0.01	0.007	0	45.6	42.6	65.8	140	132	0	34	33
2015	7	25	7	34	8	0.682	-0.072	4.029	0.01	0.007	0	45.6	42.1	66.2	140	132	0	34	34
2015	7	25	7	44	8	0.725	-0.069	4.029	0.01	0.007	0	45.6	42.6	66.2	140	132	0	34	33
2015	7	25	7	54	8	0.709	-0.072	4.029	0.01	0.007	0	45.6	42.1	66.7	140	132	0	34	34
2015	7	25	8	4	8	0.696	-0.102	4.029	0.01	0.007	0	45.6	42.6	66.2	140	132	0	34	33
2015	7	25	8	14	8	0.682	-0.118	4.029	0.013	0.01	0	45.2	42.1	67.1	140	132	0	35	34
2015	7	25	8	24	8	0.686	-0.115	4.029	0.01	0.007	0	45.6	42.6	67.5	140	132	0	34	33
2015	7	25	8	34	8	0.689	-0.079	4.029	0.013	0.01	0	46	43	67.1	141	133	0	34	33
2015	7	25	8	44	8	0.686	-0.082	4.029	0.013	0.01	0	45.6	43	67.5	140	132	0	34	32
2015	7	25	8	54	8	0.702	-0.082	4.026	0.01	0.007	0	45.6	42.6	66.7	140	132	0	34	33
2015	7	25	9	4	8	0.692	-0.082	4.026	0.01	0.007	0	45.6	42.6	66.2	140	133	0	34	34
2015	7	25	9	14	8	0.725	-0.072	4.026	0.01	0.007	0	45.6	42.6	66.2	140	133	0	34	34
2015	7	25	9	24	8	0.738	-0.115	4.022	0.01	0.007	0	45.6	42.6	67.1	140	132	0	34	33
2015	7	25	9	34	8	0.712	-0.092	4.022	0.01	0.007	0	45.6	42.6	66.7	140	132	0	34	33
2015	7	25	9	44	8	0.712	-0.118	4.019	0.01	0.007	0	44.3	42.1	67.1	138	131	0	35	33
2015	7	25	9	54	8	0.732	-0.115	4.019	0.013	0.01	0	44.7	42.1	67.1	139	131	0	35	33
2015	7	25	10	4	8	0.686	-0.098	4.019	0.013	0.01	0	45.2	42.6	67.1	139	132	0	34	33
2015	7	25	10	14	8	0.715	-0.121	4.019	0.01	0.007	0	44.3	41.7	67.1	138	130	0	35	33
2015	7	25	10	24	8	0.692	-0.115	4.019	0.01	0.007	0	44.3	41.7	67.1	137	130	0	34	33
2015	7	25	10	34	8	0.709	-0.128	4.016	0.01	0.007	0	44.7	42.1	67.5	138	131	0	34	33
2015	7	25	10	44	8	0.702	-0.115	4.016	0.013	0.01	0	44.7	41.7	67.5	138	130	0	34	33
2015	7	25	10	54	8	0.692	-0.131	4.016	0.013	0.01	0	44.7	42.1	67.9	138	131	0	34	33
2015	7	25	11	4	8	0.705	-0.138	4.016	0.01	0.007	0	44.3	41.3	67.1	137	129	0	34	33
2015	7	25	11	14	8	0.692	-0.121	4.016	0.013	0.01	0	44.3	41.3	67.1	137	130	0	34	34
2015	7	25	11	24	8	0.686	-0.135	4.016	0.01	0.007	0	44.3	41.7	61.9	137	130	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	25	11	34	8	0.692	-0.131	4.016	0.01	0.007	0	44.3	41.3	58.9	137	130	0	34	34
2015	7	25	11	44	8	0.725	-0.135	4.016	0.01	0.007	0	44.7	41.7	57.6	138	130	0	34	33
2015	7	25	11	54	8	0.673	-0.135	4.016	0.01	0.007	0	43.4	40.9	63.6	136	128	0	35	33
2015	7	25	12	4	8	0.725	-0.131	4.016	0.013	0.01	0	44.3	40.9	58.9	137	129	0	34	34
2015	7	25	12	14	8	0.673	-0.161	4.016	0.013	0.01	0	44.7	41.3	53.8	137	129	0	33	33
2015	7	25	12	24	8	0.686	-0.131	4.016	0.01	0.007	0	44.7	41.7	55.9	138	130	0	34	33
2015	7	25	12	34	8	0.673	-0.138	4.016	0.013	0.01	0	44.3	41.7	50.7	137	130	0	34	33
2015	7	25	12	44	8	0.712	-0.108	4.016	0.013	0.01	0	44.7	41.7	51.2	138	130	0	34	33
2015	7	25	12	54	8	0.725	-0.125	4.012	0.013	0.01	0	44.7	42.1	51.6	138	130	0	34	32
2015	7	25	13	4	8	0.709	-0.102	4.016	0.01	0.007	0	44.7	41.7	51.2	138	130	0	34	33
2015	7	25	13	14	8	0.702	-0.151	4.012	0.01	0.007	0	44.3	42.1	51.2	138	130	0	35	32
2015	7	25	13	24	8	0.696	-0.207	4.012	0.013	0.01	0	44.3	40.9	54.6	137	129	0	34	34
2015	7	25	13	34	8	0.679	-0.148	4.012	0.01	0.007	0	44.7	41.7	49.5	138	130	0	34	33
2015	7	25	13	44	8	0.696	-0.151	4.012	0.01	0.007	0	44.3	41.3	51.6	137	129	0	34	33
2015	7	25	13	54	8	0.719	-0.108	4.009	0.01	0.007	0	44.3	41.3	52.9	138	130	0	35	34
2015	7	25	14	4	8	0.705	-0.102	4.012	0.013	0.01	0	44.7	42.1	50.3	138	131	0	34	33
2015	7	25	14	14	8	0.709	-0.148	4.009	0.013	0.01	0	45.2	42.1	50.3	139	131	0	34	33
2015	7	25	14	24	8	0.682	-0.187	4.009	0.013	0.01	0	44.3	41.7	50.3	137	130	0	34	33
2015	7	25	14	34	8	0.659	-0.138	4.009	0.013	0.01	0	44.7	41.7	48.6	138	130	0	34	33
2015	7	25	14	44	8	0.656	-0.135	4.006	0.013	0.01	0	44.7	41.3	48.6	138	129	0	34	33
2015	7	25	14	54	8	0.705	-0.138	4.006	0.01	0.007	0	47.3	44.3	46.4	144	136	0	34	33
2015	7	25	15	4	8	0.627	-0.105	4.006	0.01	0.007	0	48.2	44.3	44.7	146	136	0	34	33
2015	7	25	15	14	8	0.686	-0.167	4.006	0.01	0.007	0	44.7	41.7	50.7	138	130	0	34	33
2015	7	25	15	24	8	0.676	-0.125	4.006	0.013	0.01	0	44.7	41.7	46.9	138	130	0	34	33
2015	7	25	15	34	8	0.692	-0.098	4.003	0.01	0.007	0	44.7	42.1	46.9	138	131	0	34	33
2015	7	25	15	44	8	0.722	-0.151	4.003	0.01	0.007	0	44.3	42.1	48.6	138	131	0	35	33
2015	7	25	15	54	8	0.646	-0.115	4.003	0.013	0.01	0	45.6	42.1	47.3	140	131	0	34	33
2015	7	25	16	4	8	0.696	-0.105	4.003	0.016	0.013	0	45.6	42.6	49.5	140	132	0	34	33
2015	7	25	16	14	8	0.663	-0.141	4.003	0.01	0.007	0	45.6	42.1	49.5	140	131	0	34	33
2015	7	25	16	24	8	0.728	-0.125	3.999	0.01	0.007	0	45.2	42.1	46	139	131	0	34	33
2015	7	25	16	34	8	0.735	-0.131	3.999	0.013	0.01	0	45.2	41.7	48.6	139	130	0	34	33
2015	7	25	16	44	8	0.709	-0.135	3.999	0.013	0.01	0	45.2	42.1	48.2	139	131	0	34	33
2015	7	25	16	54	8	0.686	-0.098	4.003	0.013	0.01	0	44.7	42.1	49.5	139	130	0	35	32
2015	7	25	17	4	8	0.705	-0.118	3.999	0.016	0.013	0	44.7	41.7	48.6	138	130	0	34	33
2015	7	25	17	14	8	0.709	-0.092	3.999	0.01	0.007	0	44.7	41.7	47.3	138	130	0	34	33
2015	7	25	17	24	8	0.696	-0.105	3.999	0.01	0.007	0	45.6	42.1	48.2	139	131	0	33	33
2015	7	25	17	34	8	0.679	-0.108	3.999	0.01	0.007	0	44.7	41.7	47.7	138	130	0	34	33
2015	7	25	17	44	8	0.712	-0.105	3.999	0.013	0.01	0	45.2	42.1	47.3	139	131	0	34	33
2015	7	25	17	54	8	0.659	-0.148	3.999	0.016	0.013	0	45.6	41.7	51.2	140	130	0	34	33
2015	7	25	18	4	8	0.673	-0.151	3.996	0.01	0.007	0	45.6	42.1	49.5	140	130	0	34	32
2015	7	25	18	14	8	0.699	-0.102	3.996	0.01	0.007	0	47.3	43.4	49	144	134	0	34	33
2015	7	25	18	24	8	0.676	-0.151	3.996	0.01	0.007	0	44.7	41.3	52.9	138	129	0	34	33
2015	7	25	18	34	8	0.709	-0.138	3.999	0.01	0.007	0	44.7	41.3	55.9	138	128	0	34	32
2015	7	25	18	44	8	0.699	-0.161	3.999	0.013	0.01	0	44.7	41.3	60.6	138	129	0	34	33
2015	7	25	18	54	8	0.682	-0.138	3.999	0.01	0.007	0	44.7	40.9	59.8	138	128	0	34	33
2015	7	25	19	4	8	0.696	-0.089	3.999	0.013	0.01	0	44.7	41.7	60.2	138	130	0	34	33
2015	7	25	19	14	8	0.702	-0.115	3.993	0.01	0.007	0	44.7	41.3	48.2	138	129	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	25	19	24	8	0.689	-0.095	3.996	0.01	0.007	0	44.7	41.7	53.3	138	130	0	34	33
2015	7	25	19	34	8	0.689	-0.072	3.996	0.01	0.007	0	46	42.1	52.9	141	132	0	34	34
2015	7	25	19	44	8	0.712	-0.062	3.996	0.013	0.01	0	45.2	42.1	54.2	139	131	0	34	33
2015	7	25	19	54	8	0.715	-0.112	3.996	0.01	0.007	0	45.6	42.1	52.5	139	131	0	33	33
2015	7	25	20	4	8	0.699	-0.082	3.999	0.01	0.007	0	46	43.4	56.3	141	133	0	34	32
2015	7	25	20	14	8	0.705	-0.062	3.999	0.013	0.01	0	46	43.4	55.5	141	133	0	34	32
2015	7	25	20	24	8	0.669	-0.059	3.999	0.01	0.007	0	46.9	43.9	58.9	143	135	0	34	33
2015	7	25	20	34	8	0.712	-0.072	3.999	0.01	0.007	0	46.9	43	59.8	143	134	0	34	34
2015	7	25	20	44	8	0.712	-0.095	3.999	0.013	0.01	0	46.4	43.4	54.2	142	134	0	34	33
2015	7	25	20	54	8	0.64	-0.072	3.999	0.01	0.007	0	46.4	43.4	60.2	142	133	0	34	32
2015	7	25	21	4	8	0.696	-0.089	3.996	0.01	0.007	0	46.9	44.3	55	144	136	0	35	33
2015	7	25	21	14	8	0.696	-0.102	3.999	0.01	0.007	0	46.4	43.4	58.9	142	134	0	34	33
2015	7	25	21	24	8	0.709	-0.098	3.999	0.01	0.007	0	46	43	65.8	141	133	0	34	33
2015	7	25	21	34	8	0.696	-0.079	3.999	0.013	0.01	0	46.9	43.4	63.2	143	134	0	34	33
2015	7	25	21	44	8	0.692	-0.069	3.999	0.016	0.013	0	46.4	44.3	60.6	143	135	0	35	32
2015	7	25	21	54	8	0.676	-0.092	3.999	0.016	0.013	0	46	43	67.9	141	133	0	34	33
2015	7	25	22	4	8	0.705	-0.089	4.003	0.01	0.007	0	46.4	43.4	67.1	142	134	0	34	33
2015	7	25	22	14	8	0.696	-0.102	4.003	0.01	0.007	0	46	43.4	67.1	142	134	0	35	33
2015	7	25	22	24	8	0.709	-0.075	4.003	0.01	0.007	0	45.6	43	67.1	141	133	0	35	33
2015	7	25	22	34	8	0.692	-0.069	4.003	0.01	0.007	0	45.6	43	67.5	140	133	0	34	33
2015	7	25	22	44	8	0.682	-0.039	4.003	0.016	0.013	0	46.9	43.4	67.9	143	134	0	34	33
2015	7	25	22	54	8	0.696	-0.072	4.003	0.01	0.007	0	46	43	68.8	141	133	0	34	33
2015	7	25	23	4	8	0.682	-0.079	4.003	0.01	0.007	0	46.4	43.4	68.8	142	133	0	34	32
2015	7	25	23	14	8	0.676	-0.085	4.003	0.01	0.007	0	46	43	68.8	142	134	0	35	34
2015	7	25	23	24	8	0.696	-0.089	4.003	0.01	0.007	0	45.6	43	69.7	140	132	0	34	32
2015	7	25	23	34	8	0.682	-0.052	4.003	0.013	0.01	0	46.4	43.4	68.4	142	134	0	34	33
2015	7	25	23	44	8	0.692	-0.036	4.003	0.013	0.01	0	46.9	43.9	68.8	143	135	0	34	33
2015	7	25	23	54	8	0.659	-0.059	4.003	0.013	0.01	0	46.4	43.4	70.1	142	134	0	34	33
2015	7	26	0	4	8	0.696	-0.079	4.003	0.01	0.007	0	45.6	42.6	69.7	140	132	0	34	33
2015	7	26	0	14	8	0.669	-0.066	4.003	0.01	0.007	0	46	43	69.7	141	133	0	34	33
2015	7	26	0	24	8	0.705	-0.069	4.003	0.01	0.007	0	46	42.6	68.8	141	132	0	34	33
2015	7	26	0	34	8	0.689	-0.089	4.003	0.013	0.01	0	44.7	42.1	68.8	139	131	0	35	33
2015	7	26	0	44	8	0.689	-0.056	4.003	0.01	0.007	0	46.4	43.4	69.7	142	134	0	34	33
2015	7	26	0	54	8	0.682	-0.082	4.003	0.01	0.007	0	45.6	42.1	68.8	140	132	0	34	34
2015	7	26	1	4	8	0.692	-0.085	4.003	0.013	0.01	0	45.2	42.1	67.1	139	131	0	34	33
2015	7	26	1	14	8	0.676	-0.098	4.003	0.013	0.01	0	46	43	68.8	141	133	0	34	33
2015	7	26	1	24	8	0.656	-0.062	4.006	0.01	0.007	0	46	43	69.7	141	133	0	34	33
2015	7	26	1	34	8	0.692	-0.052	4.003	0.016	0.016	0	46	43	70.1	141	133	0	34	33
2015	7	26	1	44	8	0.679	-0.098	4.003	0.01	0.007	0	46	42.6	67.5	141	132	0	34	33
2015	7	26	1	54	8	0.676	-0.085	4.003	0.01	0.007	0	46.4	43.4	69.2	142	134	0	34	33
2015	7	26	2	4	8	0.709	-0.092	4.003	0.01	0.007	0	46	42.6	70.1	140	132	0	33	33
2015	7	26	2	14	8	0.719	-0.098	4.003	0.01	0.007	0	46	43	69.7	141	133	0	34	33
2015	7	26	2	24	8	0.692	-0.085	4.006	0.01	0.007	0	46	43.4	70.5	141	134	0	34	33
2015	7	26	2	34	8	0.676	-0.049	4.006	0.013	0.01	0	46	43.4	70.1	141	133	0	34	32
2015	7	26	2	44	8	0.696	-0.098	4.006	0.01	0.007	0	46	43.4	70.1	141	133	0	34	32
2015	7	26	2	54	8	0.712	-0.085	4.003	0.01	0.007	0	46	43	70.1	141	133	0	34	33
2015	7	26	3	4	8	0.722	-0.102	4.003	0.01	0.007	0	46	43	70.1	141	133	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	26	3	14	8	0.715	-0.089	4.006	0.01	0.007	0	46.4	43.4	70.1	142	134	0	34	33
2015	7	26	3	24	8	0.682	-0.052	4.006	0.013	0.01	0	45.6	43.4	70.5	141	134	0	35	33
2015	7	26	3	34	8	0.692	-0.052	4.003	0.01	0.007	0	46.4	43	70.5	142	133	0	34	33
2015	7	26	3	44	8	0.709	-0.098	4.003	0.016	0.016	0	46.4	43.4	69.2	142	134	0	34	33
2015	7	26	3	54	8	0.692	-0.095	4.003	0.01	0.007	0	46.4	43.4	69.7	142	134	0	34	33
2015	7	26	4	4	8	0.686	-0.069	4.006	0.01	0.007	0	47.3	43.9	70.1	144	135	0	34	33
2015	7	26	4	14	8	0.666	-0.085	4.006	0.013	0.01	0	46.4	43.4	70.1	142	134	0	34	33
2015	7	26	4	24	8	0.679	-0.092	4.006	0.01	0.007	0	46.4	43	70.1	142	133	0	34	33
2015	7	26	4	34	8	0.692	-0.082	4.003	0.013	0.01	0	46	43	70.1	141	133	0	34	33
2015	7	26	4	44	8	0.669	-0.069	4.003	0.01	0.007	0	46.9	43.4	70.1	143	134	0	34	33
2015	7	26	4	54	8	0.692	-0.118	4.003	0.01	0.007	0	46.4	43	70.5	142	133	0	34	33
2015	7	26	5	4	8	0.709	-0.075	4.003	0.01	0.007	0	46.4	43.4	70.1	142	134	0	34	33
2015	7	26	5	14	8	0.712	-0.098	4.003	0.01	0.007	0	46.4	43.4	71.4	142	134	0	34	33
2015	7	26	5	24	8	0.705	-0.082	4.003	0.01	0.007	0	46	43	70.5	141	133	0	34	33
2015	7	26	5	34	8	0.676	-0.121	4.003	0.013	0.01	0	46.4	43	70.5	142	133	0	34	33
2015	7	26	5	44	8	0.663	-0.082	4.003	0.016	0.013	0	46	42.6	70.5	141	132	0	34	33
2015	7	26	5	54	8	0.712	-0.092	4.003	0.013	0.01	0	46	42.6	71	141	132	0	34	33
2015	7	26	6	4	8	0.689	-0.085	4.003	0.01	0.007	0	46	43	70.5	141	133	0	34	33
2015	7	26	6	14	8	0.735	-0.092	4.003	0.01	0.007	0	45.6	42.6	70.1	140	132	0	34	33
2015	7	26	6	24	8	0.682	-0.072	4.003	0.01	0.007	0	46	42.6	70.5	141	132	0	34	33
2015	7	26	6	34	8	0.745	-0.092	4.003	0.013	0.01	0	45.6	42.6	71	140	132	0	34	33
2015	7	26	6	44	8	0.689	-0.095	4.003	0.013	0.01	0	46	42.6	71	141	132	0	34	33
2015	7	26	6	54	8	0.709	-0.082	4.003	0.01	0.007	0	45.2	42.1	70.5	140	131	0	35	33
2015	7	26	7	4	8	0.702	-0.066	4.003	0.01	0.007	0	45.6	42.6	69.7	141	132	0	35	33
2015	7	26	7	14	8	0.712	-0.066	4.003	0.01	0.007	0	45.6	42.6	70.1	140	132	0	34	33
2015	7	26	7	24	8	0.689	-0.082	4.003	0.01	0.007	0	46.4	43	70.1	142	133	0	34	33
2015	7	26	7	34	8	0.692	-0.102	4.003	0.01	0.007	0	46	43	70.1	141	133	0	34	33
2015	7	26	7	44	8	0.692	-0.082	4.003	0.013	0.01	0	46	43	70.1	141	133	0	34	33
2015	7	26	7	54	8	0.719	-0.085	4.003	0.013	0.01	0	45.2	42.1	69.7	140	131	0	35	33
2015	7	26	8	4	8	0.692	-0.079	4.003	0.01	0.007	0	45.6	42.6	70.1	140	132	0	34	33
2015	7	26	8	14	8	0.702	-0.115	4.003	0.013	0.01	0	46	42.6	70.5	141	132	0	34	33
2015	7	26	8	24	8	0.705	-0.075	4.003	0.01	0.007	0	45.2	42.1	70.5	140	131	0	35	33
2015	7	26	8	34	8	0.686	-0.118	4.003	0.013	0.01	0	45.2	42.1	71	139	131	0	34	33
2015	7	26	8	44	8	0.712	-0.102	4.003	0.013	0.01	0	45.6	43	70.5	141	133	0	35	33
2015	7	26	8	54	8	0.705	-0.089	4.003	0.01	0.007	0	45.6	42.6	70.5	140	132	0	34	33
2015	7	26	9	4	8	0.732	-0.098	4.003	0.01	0.007	0	46	42.6	70.5	141	133	0	34	34
2015	7	26	9	14	8	0.719	-0.085	4.003	0.01	0.007	0	45.6	42.6	71	140	132	0	34	33
2015	7	26	9	24	8	0.722	-0.098	4.003	0.013	0.01	0	45.6	42.6	71.4	140	132	0	34	33
2015	7	26	9	34	8	0.696	-0.092	4.003	0.013	0.01	0	45.6	42.1	71.4	140	132	0	34	34
2015	7	26	9	44	8	0.673	-0.112	4.003	0.01	0.007	0	45.2	42.1	72.2	139	131	0	34	33
2015	7	26	9	54	8	0.725	-0.115	4.003	0.01	0.007	0	44.7	41.7	71.4	139	130	0	35	33
2015	7	26	10	4	8	0.702	-0.098	4.003	0.01	0.007	0	44.7	42.1	72.2	139	131	0	35	33
2015	7	26	10	14	8	0.702	-0.085	4.003	0.01	0.007	0	45.2	42.1	71.8	139	132	0	34	34
2015	7	26	10	24	8	0.699	-0.138	4.003	0.01	0.007	0	44.3	41.7	71.4	138	130	0	35	33
2015	7	26	10	34	8	0.709	-0.148	4.003	0.013	0.01	0	44.7	41.7	71	138	130	0	34	33
2015	7	26	10	44	8	0.696	-0.131	4.003	0.013	0.01	0	45.2	42.6	63.6	139	132	0	34	33
2015	7	26	10	54	8	0.673	-0.131	3.999	0.01	0.007	0	44.7	41.7	64.9	138	130	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	26	11	4	8	0.676	-0.128	3.999	0.01	0.007	0	44.7	41.3	66.7	138	129	0	34	33
2015	7	26	11	14	8	0.702	-0.157	3.999	0.01	0.007	0	44.3	41.3	58.5	137	129	0	34	33
2015	7	26	11	24	8	0.673	-0.131	3.999	0.016	0.013	0	44.3	41.3	63.6	137	129	0	34	33
2015	7	26	11	34	8	0.692	-0.131	3.999	0.013	0.01	0	44.3	41.3	60.6	137	129	0	34	33
2015	7	26	11	44	8	0.666	-0.135	3.996	0.01	0.007	0	44.3	41.3	54.6	137	129	0	34	33
2015	7	26	11	54	8	0.696	-0.125	3.996	0.01	0.007	0	44.7	41.7	60.2	138	130	0	34	33
2015	7	26	12	4	8	0.705	-0.105	3.996	0.01	0.007	0	44.7	41.7	54.2	138	130	0	34	33
2015	7	26	12	14	8	0.676	-0.171	3.996	0.013	0.01	0	44.3	41.7	57.2	137	130	0	34	33
2015	7	26	12	24	8	0.666	-0.135	3.993	0.013	0.01	0	44.7	41.7	53.3	138	130	0	34	33
2015	7	26	12	34	8	0.682	-0.161	3.993	0.013	0.01	0	44.7	41.7	54.6	138	130	0	34	33
2015	7	26	12	44	8	0.679	-0.141	3.993	0.01	0.007	0	44.7	41.7	48.2	138	130	0	34	33
2015	7	26	12	54	8	0.689	-0.144	3.993	0.01	0.007	0	44.3	41.3	50.3	138	130	0	35	34
2015	7	26	13	4	8	0.686	-0.148	3.99	0.01	0.007	0	44.3	41.7	47.3	138	130	0	35	33
2015	7	26	13	14	8	0.692	-0.135	3.99	0.01	0.007	0	44.3	41.3	47.3	138	129	0	35	33
2015	7	26	13	24	8	0.673	-0.144	3.986	0.013	0.01	0	45.2	42.6	49.5	139	132	0	34	33
2015	7	26	13	34	8	0.659	-0.118	3.99	0.013	0.01	0	45.2	42.1	49.5	139	131	0	34	33
2015	7	26	13	44	8	0.676	-0.141	3.986	0.01	0.007	0	45.2	42.1	47.7	139	131	0	34	33
2015	7	26	13	54	8	0.702	-0.151	3.986	0.01	0.007	0	44.7	42.1	48.2	139	131	0	35	33
2015	7	26	14	4	8	0.682	-0.135	3.98	0.013	0.01	0	45.2	42.1	57.6	139	131	0	34	33
2015	7	26	14	14	8	0.689	-0.138	3.983	0.013	0.01	0	45.6	42.1	49.5	140	131	0	34	33
2015	7	26	14	24	8	0.676	-0.108	3.983	0.01	0.007	0	45.6	42.1	52	140	131	0	34	33
2015	7	26	14	34	8	0.705	-0.089	3.98	0.01	0.007	0	46	43	51.2	141	133	0	34	33
2015	7	26	14	44	8	0.676	-0.138	3.983	0.013	0.01	0	45.6	43	49	140	132	0	34	32
2015	7	26	14	54	8	0.682	-0.128	3.983	0.013	0.01	0	45.6	42.6	48.6	140	132	0	34	33
2015	7	26	15	4	8	0.676	-0.115	3.98	0.013	0.01	0	45.2	42.1	47.3	140	131	0	35	33
2015	7	26	15	14	8	0.689	-0.056	3.98	0.013	0.01	0	45.6	42.6	49	141	132	0	35	33
2015	7	26	15	24	8	0.673	-0.151	3.976	0.01	0.007	0	45.2	42.6	49.9	139	132	0	34	33
2015	7	26	15	34	8	0.696	-0.125	3.976	0.01	0.007	0	45.2	42.6	47.7	140	132	0	35	33
2015	7	26	15	44	8	0.692	-0.125	3.976	0.016	0.013	0	45.6	42.6	49.9	140	132	0	34	33
2015	7	26	15	54	8	0.663	-0.062	3.98	0.013	0.01	0	45.6	42.1	48.2	140	131	0	34	33
2015	7	26	16	4	8	0.679	-0.115	3.976	0.01	0.007	0	45.6	42.6	49	140	132	0	34	33
2015	7	26	16	14	8	0.653	-0.108	3.976	0.01	0.007	0	46	42.6	47.7	140	132	0	33	33
2015	7	26	16	24	8	0.676	-0.108	3.976	0.01	0.007	0	45.6	43	49	140	133	0	34	33
2015	7	26	16	34	8	0.712	-0.079	3.976	0.01	0.007	0	45.6	42.6	49.5	140	132	0	34	33
2015	7	26	16	44	8	0.692	-0.121	3.973	0.01	0.007	0	45.2	42.6	49.9	140	132	0	35	33
2015	7	26	16	54	8	0.689	-0.118	3.973	0.01	0.007	0	45.6	43	48.6	140	132	0	34	32
2015	7	26	17	4	8	0.722	-0.121	3.973	0.01	0.007	0	45.6	42.6	49.9	140	132	0	34	33
2015	7	26	17	14	8	0.686	-0.141	3.973	0.016	0.016	0	45.2	42.1	50.7	139	131	0	34	33
2015	7	26	17	24	8	0.663	-0.118	3.973	0.016	0.013	0	45.2	42.1	48.6	139	131	0	34	33
2015	7	26	17	34	8	0.679	-0.115	3.97	0.01	0.007	0	45.2	42.1	52	139	131	0	34	33
2015	7	26	17	44	8	0.725	-0.148	3.97	0.01	0.007	0	45.2	42.6	49.9	139	132	0	34	33
2015	7	26	17	54	8	0.699	-0.112	3.967	0.01	0.007	0	45.2	42.1	56.8	139	131	0	34	33
2015	7	26	18	4	8	0.725	-0.135	3.967	0.016	0.016	0	45.2	41.7	54.2	139	131	0	34	34
2015	7	26	18	14	8	0.696	-0.098	3.97	0.013	0.01	0	45.2	42.1	54.6	139	131	0	34	33
2015	7	26	18	24	8	0.679	-0.125	3.97	0.01	0.007	0	45.2	42.1	55.9	139	131	0	34	33
2015	7	26	18	34	8	0.705	-0.118	3.967	0.01	0.007	0	44.7	41.7	61.1	138	130	0	34	33
2015	7	26	18	44	8	0.709	-0.082	3.97	0.013	0.01	0	45.2	42.1	58	139	131	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	26	18	54	8	0.712	-0.085	3.967	0.013	0.01	0	45.6	42.6	39.6	140	132	0	34	33
2015	7	26	19	4	8	0.709	-0.135	3.967	0.016	0.013	0	45.2	42.1	61.9	139	130	0	34	32
2015	7	26	19	14	8	0.686	-0.115	3.967	0.01	0.007	0	45.2	42.6	63.6	140	132	0	35	33
2015	7	26	19	24	8	0.696	-0.082	3.967	0.013	0.01	0	46	43	71	141	133	0	34	33
2015	7	26	19	34	8	0.725	-0.105	3.967	0.013	0.01	0	46	42.6	69.7	141	132	0	34	33
2015	7	26	19	44	8	0.659	-0.102	3.967	0.01	0.007	0	46.4	43.4	70.5	142	134	0	34	33
2015	7	26	19	54	8	0.666	-0.095	3.967	0.01	0.007	0	46.9	43.9	70.5	143	135	0	34	33
2015	7	26	20	4	8	0.673	-0.095	3.97	0.013	0.01	0	47.3	44.3	69.7	144	136	0	34	33
2015	7	26	20	14	8	0.686	-0.069	3.97	0.013	0.01	0	46.9	43.9	70.5	143	135	0	34	33
2015	7	26	20	24	8	0.689	-0.089	3.97	0.01	0.007	0	46.9	43.9	70.5	144	135	0	35	33
2015	7	26	20	34	8	0.712	-0.062	3.97	0.01	0.007	0	47.7	43.9	70.1	145	136	0	34	34
2015	7	26	20	44	8	0.659	-0.079	3.97	0.01	0.007	0	47.3	44.3	66.2	144	136	0	34	33
2015	7	26	20	54	8	0.699	-0.079	3.97	0.01	0.007	0	47.3	44.3	69.7	144	136	0	34	33
2015	7	26	21	4	8	0.676	-0.105	3.97	0.016	0.016	0	47.3	44.3	70.5	144	136	0	34	33
2015	7	26	21	14	8	0.689	-0.062	3.97	0.01	0.007	0	46.4	43.4	68.8	143	135	0	35	34
2015	7	26	21	24	8	0.682	-0.079	3.97	0.013	0.01	0	47.3	44.3	69.7	144	136	0	34	33
2015	7	26	21	34	8	0.696	-0.066	3.97	0.01	0.007	0	46.9	43.9	68.4	143	135	0	34	33
2015	7	26	21	44	8	0.646	-0.098	3.97	0.013	0.01	0	47.3	44.3	68.4	144	136	0	34	33
2015	7	26	21	54	8	0.722	-0.115	3.97	0.01	0.007	0	46.4	43.4	65.8	142	134	0	34	33
2015	7	26	22	4	8	0.712	-0.085	3.97	0.01	0.007	0	46.9	44.3	70.5	143	135	0	34	32
2015	7	26	22	14	8	0.676	-0.082	3.97	0.01	0.007	0	46.9	43.9	71	143	135	0	34	33
2015	7	26	22	24	8	0.673	-0.112	3.97	0.01	0.007	0	46.9	43.9	69.2	143	135	0	34	33
2015	7	26	22	34	8	0.686	-0.066	3.97	0.01	0.007	0	46.4	43.9	69.7	143	135	0	35	33
2015	7	26	22	44	8	0.686	-0.075	3.97	0.013	0.01	0	47.7	44.7	68.8	145	137	0	34	33
2015	7	26	22	54	8	0.692	-0.102	3.97	0.013	0.01	0	47.3	43.9	69.7	144	135	0	34	33
2015	7	26	23	4	8	0.659	-0.098	3.97	0.016	0.013	0	47.3	44.7	70.1	144	136	0	34	32
2015	7	26	23	14	8	0.666	-0.085	3.97	0.01	0.007	0	47.3	44.3	70.1	144	136	0	34	33
2015	7	26	23	24	8	0.673	-0.052	3.97	0.016	0.013	0	48.2	45.2	70.5	146	138	0	34	33
2015	7	26	23	34	8	0.686	-0.085	3.97	0.013	0.01	0	47.3	43.9	69.7	144	135	0	34	33
2015	7	26	23	44	8	0.699	-0.056	3.97	0.013	0.01	0	47.3	44.7	69.2	144	136	0	34	32
2015	7	26	23	54	8	0.705	-0.089	3.97	0.01	0.007	0	47.3	44.3	68.8	144	136	0	34	33
2015	7	27	0	4	8	0.696	-0.066	3.97	0.013	0.01	0	47.3	44.3	68.8	144	136	0	34	33
2015	7	27	0	14	8	0.679	-0.072	3.97	0.01	0.007	0	47.7	44.7	69.7	145	137	0	34	33
2015	7	27	0	24	8	0.682	-0.072	3.97	0.01	0.007	0	47.3	43.9	69.2	144	135	0	34	33
2015	7	27	0	34	8	0.676	-0.085	3.97	0.01	0.007	0	46	43.4	64.1	142	134	0	35	33
2015	7	27	0	44	8	0.686	-0.066	3.97	0.01	0.007	0	46.9	43.9	70.1	143	135	0	34	33
2015	7	27	0	54	8	0.692	-0.066	3.97	0.01	0.007	0	46.4	43.4	69.2	142	134	0	34	33
2015	7	27	1	4	8	0.669	-0.102	3.97	0.01	0.007	0	46.9	43.9	69.2	143	135	0	34	33
2015	7	27	1	14	8	0.696	-0.059	3.97	0.01	0.007	0	47.3	44.3	66.2	144	136	0	34	33
2015	7	27	1	24	8	0.709	-0.108	3.973	0.01	0.007	0	46.4	43	69.2	142	133	0	34	33
2015	7	27	1	34	8	0.719	-0.069	3.973	0.01	0.007	0	46	43.4	69.2	142	134	0	35	33
2015	7	27	1	44	8	0.705	-0.056	3.973	0.013	0.01	0	46.9	43.4	69.7	143	135	0	34	34
2015	7	27	1	54	8	0.679	-0.102	3.973	0.01	0.007	0	47.3	44.3	66.7	144	136	0	34	33
2015	7	27	2	4	8	0.709	-0.075	3.973	0.013	0.01	0	46.9	43.9	65.4	143	135	0	34	33
2015	7	27	2	14	8	0.682	-0.072	3.973	0.01	0.007	0	46.9	44.3	62.8	144	136	0	35	33
2015	7	27	2	24	8	0.686	-0.059	3.973	0.016	0.013	0	47.3	44.3	67.1	144	136	0	34	33
2015	7	27	2	34	8	0.659	-0.098	3.973	0.01	0.007	0	47.3	44.3	68.4	144	136	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	27	2	44	8	0.686	-0.098	3.973	0.01	0.007	0	46	43	69.2	142	134	0	35	34
2015	7	27	2	54	8	0.689	-0.144	3.973	0.01	0.007	0	46.9	43.9	68.4	143	135	0	34	33
2015	7	27	3	4	8	0.669	-0.082	3.973	0.013	0.01	0	47.3	44.3	67.5	144	136	0	34	33
2015	7	27	3	14	8	0.686	-0.049	3.973	0.013	0.01	0	46.4	43.9	61.9	142	135	0	34	33
2015	7	27	3	24	8	0.682	-0.089	3.973	0.013	0.01	0	46	43.4	68.8	141	134	0	34	33
2015	7	27	3	34	8	0.702	-0.082	3.973	0.01	0.007	0	46	43.9	66.2	141	135	0	34	33
2015	7	27	3	44	8	0.673	-0.079	3.973	0.01	0.007	0	46.4	43.9	59.3	142	135	0	34	33
2015	7	27	3	54	8	0.696	-0.075	3.973	0.013	0.01	0	46.9	44.3	58.5	143	136	0	34	33
2015	7	27	4	4	8	0.702	-0.036	3.973	0.01	0.007	0	46.9	43.9	63.2	143	136	0	34	34
2015	7	27	4	14	8	0.673	-0.085	3.973	0.016	0.013	0	46.4	44.3	54.2	143	136	0	35	33
2015	7	27	4	24	8	0.686	-0.098	3.976	0.01	0.007	0	47.3	44.7	51.6	144	137	0	34	33
2015	7	27	4	34	8	0.696	-0.043	3.973	0.01	0.007	0	47.7	44.7	55	145	138	0	34	34
2015	7	27	4	44	8	0.696	-0.069	3.976	0.01	0.007	0	47.3	44.7	51.6	144	137	0	34	33
2015	7	27	4	54	8	0.692	-0.085	3.973	0.01	0.007	0	47.3	44.3	55.9	144	136	0	34	33
2015	7	27	5	4	8	0.692	-0.079	3.973	0.016	0.016	0	46.9	44.7	53.8	144	137	0	35	33
2015	7	27	5	14	8	0.676	-0.059	3.973	0.01	0.007	0	47.3	44.7	54.2	144	137	0	34	33
2015	7	27	5	24	8	0.673	-0.102	3.973	0.01	0.007	0	47.7	44.3	56.8	144	136	0	33	33
2015	7	27	5	34	8	0.692	-0.102	3.97	0.01	0.007	0	46.9	44.3	62.8	143	136	0	34	33
2015	7	27	5	44	8	0.676	-0.059	3.973	0.013	0.01	0	47.3	44.3	62.4	144	136	0	34	33
2015	7	27	5	54	8	0.659	-0.102	3.97	0.01	0.007	0	47.3	44.3	61.9	144	136	0	34	33
2015	7	27	6	4	8	0.712	-0.075	3.973	0.01	0.007	0	46.9	44.7	53.3	144	137	0	35	33
2015	7	27	6	14	8	0.689	-0.075	3.973	0.01	0.007	0	47.3	44.3	52.5	144	136	0	34	33
2015	7	27	6	24	8	0.712	-0.102	3.973	0.01	0.007	0	47.3	44.3	52.9	144	136	0	34	33
2015	7	27	6	34	8	0.689	-0.108	3.976	0.013	0.01	0	46.9	44.3	52.5	144	136	0	35	33
2015	7	27	6	44	8	0.659	-0.089	3.973	0.013	0.01	0	46.9	44.3	52.5	144	136	0	35	33
2015	7	27	6	54	8	0.709	-0.059	3.976	0.01	0.007	0	46.4	43.9	52.5	143	135	0	35	33
2015	7	27	7	4	8	0.679	-0.049	3.976	0.01	0.007	0	46.4	43.9	50.3	143	135	0	35	33
2015	7	27	7	14	8	0.673	-0.085	3.976	0.01	0.007	0	47.3	44.3	51.2	144	136	0	34	33
2015	7	27	7	24	8	0.696	-0.098	3.976	0.01	0.007	0	47.7	44.7	49	145	137	0	34	33
2015	7	27	7	34	8	0.659	-0.036	3.976	0.01	0.007	0	47.7	45.2	49.5	146	138	0	35	33
2015	7	27	7	44	8	0.669	-0.102	3.976	0.013	0.01	0	49.5	46.4	49	149	141	0	34	33
2015	7	27	7	54	8	0.643	-0.072	3.976	0.016	0.013	0	49	46	48.6	149	141	0	35	34
2015	7	27	8	4	8	0.656	-0.095	3.976	0.016	0.013	0	48.6	46	48.6	148	140	0	35	33
2015	7	27	8	14	8	0.692	-0.066	3.976	0.01	0.007	0	49	46	50.3	148	140	0	34	33
2015	7	27	8	24	8	0.715	-0.066	3.976	0.013	0.01	0	49	46.4	48.2	149	141	0	35	33
2015	7	27	8	34	8	0.705	-0.062	3.976	0.013	0.01	0	49.9	46.9	49.5	150	142	0	34	33
2015	7	27	8	44	8	0.689	-0.089	3.976	0.01	0.007	0	49.9	47.3	50.3	150	143	0	34	33
2015	7	27	8	54	8	0.663	-0.075	3.976	0.01	0.007	0	49.5	46.4	49	149	141	0	34	33
2015	7	27	9	4	8	0.669	-0.085	3.973	0.01	0.007	0	49	46	49.9	148	140	0	34	33
2015	7	27	9	14	8	0.669	-0.085	3.973	0.01	0.007	0	48.2	45.6	49	146	139	0	34	33
2015	7	27	9	24	8	0.699	-0.072	3.973	0.013	0.01	0	47.7	44.7	51.2	145	137	0	34	33
2015	7	27	9	34	8	0.686	-0.075	3.973	0.01	0.007	0	47.7	45.2	51.2	146	138	0	35	33
2015	7	27	9	44	8	0.663	-0.066	3.973	0.01	0.007	0	47.3	45.2	51.2	145	138	0	35	33
2015	7	27	9	54	8	0.676	-0.095	3.97	0.01	0.007	0	47.3	44.3	51.6	145	137	0	35	34
2015	7	27	10	4	8	0.696	-0.069	3.973	0.01	0.007	0	47.3	44.3	51.6	144	136	0	34	33
2015	7	27	10	14	8	0.679	-0.102	3.97	0.013	0.01	0	47.7	44.3	53.8	145	137	0	34	34
2015	7	27	10	24	8	0.676	-0.089	3.97	0.016	0.013	0	46.9	43.9	52.5	143	136	0	34	34

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	27	10	34	8	0.669	-0.082	3.97	0.016	0.013	0	47.7	44.7	54.6	145	137	0	34	33
2015	7	27	10	44	8	0.689	-0.072	3.97	0.01	0.007	0	47.3	44.7	54.2	144	137	0	34	33
2015	7	27	10	54	8	0.666	-0.085	3.967	0.01	0.007	0	47.3	44.7	54.6	144	137	0	34	33
2015	7	27	11	4	8	0.696	-0.092	3.967	0.016	0.016	0	47.3	44.7	56.3	144	137	0	34	33
2015	7	27	11	14	8	0.709	-0.082	3.967	0.01	0.007	0	47.3	43.9	58	144	136	0	34	34
2015	7	27	11	24	8	0.676	-0.075	3.967	0.01	0.007	0	46.9	44.3	61.5	143	136	0	34	33
2015	7	27	11	34	8	0.709	-0.095	3.967	0.013	0.01	0	46.9	44.3	56.3	143	136	0	34	33
2015	7	27	11	44	8	0.702	-0.102	3.963	0.013	0.01	0	46.9	43.9	54.2	143	135	0	34	33
2015	7	27	11	54	8	0.65	-0.085	3.963	0.01	0.007	0	46.9	44.3	65.4	143	136	0	34	33
2015	7	27	12	4	8	0.673	-0.079	3.963	0.016	0.016	0	46.9	43.9	53.3	144	136	0	35	34
2015	7	27	12	14	8	0.699	-0.102	3.963	0.013	0.01	0	46.9	43.9	61.9	143	135	0	34	33
2015	7	27	12	24	8	0.696	-0.098	3.963	0.013	0.01	0	46.4	43.9	67.9	142	135	0	34	33
2015	7	27	12	34	8	0.692	-0.115	3.96	0.01	0.007	0	46.9	44.3	67.5	143	136	0	34	33
2015	7	27	12	44	8	0.656	-0.095	3.96	0.01	0.007	0	46.4	43.9	63.6	142	135	0	34	33
2015	7	27	12	54	8	0.673	-0.089	3.96	0.01	0.007	0	46	43	61.9	141	133	0	34	33
2015	7	27	13	4	8	0.686	-0.098	3.96	0.01	0.007	0	46.4	43	60.6	142	134	0	34	34
2015	7	27	13	14	8	0.686	-0.092	3.96	0.013	0.01	0	46.4	43.9	67.1	142	135	0	34	33
2015	7	27	13	24	8	0.689	-0.082	3.96	0.013	0.01	0	46.4	43	64.5	142	134	0	34	34
2015	7	27	13	34	8	0.663	-0.108	3.957	0.013	0.01	0	46	42.6	68.8	141	133	0	34	34
2015	7	27	13	44	8	0.709	-0.069	3.957	0.01	0.007	0	45.6	43.4	67.5	141	134	0	35	33
2015	7	27	13	54	8	0.702	-0.075	3.957	0.01	0.007	0	46.4	43.4	66.2	142	134	0	34	33
2015	7	27	14	4	8	0.692	-0.082	3.957	0.01	0.007	0	44.7	42.6	66.7	139	132	0	35	33
2015	7	27	14	14	8	0.669	-0.108	3.957	0.013	0.01	0	46	43.9	64.5	142	135	0	35	33
2015	7	27	14	24	8	0.679	-0.085	3.953	0.01	0.007	0	45.6	42.6	67.5	140	132	0	34	33
2015	7	27	14	34	8	0.719	-0.069	3.953	0.013	0.01	0	45.2	43	63.6	140	133	0	35	33
2015	7	27	14	44	8	0.679	-0.118	3.953	0.013	0.01	0	45.2	43	65.8	140	133	0	35	33
2015	7	27	14	54	8	0.715	-0.112	3.953	0.013	0.01	0	46	43.4	66.7	141	134	0	34	33
2015	7	27	15	4	8	0.65	-0.095	3.95	0.01	0.007	0	45.6	43	66.7	140	133	0	34	33
2015	7	27	15	14	8	0.679	-0.098	3.947	0.01	0.007	0	45.2	42.1	65.8	139	132	0	34	34
2015	7	27	15	24	8	0.623	-0.148	3.944	0.016	0.013	0	44.7	42.1	64.9	138	131	0	34	33
2015	7	27	15	34	8	0.692	-0.115	3.944	0.01	0.007	0	44.7	42.1	59.8	138	131	0	34	33
2015	7	27	15	44	8	0.676	-0.089	3.944	0.01	0.007	0	45.2	43	65.4	140	133	0	35	33
2015	7	27	15	54	8	0.686	-0.118	3.94	0.01	0.007	0	45.2	42.6	66.2	140	132	0	35	33
2015	7	27	16	4	8	0.682	-0.105	3.94	0.01	0.007	0	45.2	42.6	65.8	139	132	0	34	33
2015	7	27	16	14	8	0.699	-0.154	3.94	0.01	0.007	0	45.2	42.6	67.9	139	132	0	34	33
2015	7	27	16	24	8	0.669	-0.154	3.94	0.013	0.01	0	45.2	42.6	67.5	139	132	0	34	33
2015	7	27	16	34	8	0.673	-0.082	3.94	0.016	0.013	0	45.6	43	61.9	140	133	0	34	33
2015	7	27	16	44	8	0.673	-0.108	3.94	0.013	0.01	0	45.6	43	61.9	140	133	0	34	33
2015	7	27	16	54	8	0.673	-0.115	3.94	0.013	0.01	0	45.2	42.6	55	139	132	0	34	33
2015	7	27	17	4	8	0.696	-0.131	3.94	0.013	0.01	0	45.2	42.6	54.6	139	132	0	34	33
2015	7	27	17	14	8	0.692	-0.092	3.94	0.01	0.007	0	45.6	43	51.2	140	133	0	34	33
2015	7	27	17	24	8	0.732	-0.102	3.94	0.016	0.013	0	45.6	43	58	140	133	0	34	33
2015	7	27	17	34	8	0.682	-0.105	3.937	0.01	0.007	0	44.7	42.1	57.2	139	131	0	35	33
2015	7	27	17	44	8	0.696	-0.098	3.937	0.016	0.016	0	45.2	42.6	68.4	139	132	0	34	33
2015	7	27	17	54	8	0.673	-0.102	3.937	0.013	0.01	0	46.9	43.4	66.7	142	134	0	33	33
2015	7	27	18	4	8	0.692	-0.105	3.937	0.01	0.007	0	46	43.4	67.5	141	134	0	34	33
2015	7	27	18	14	8	0.712	-0.092	3.937	0.013	0.01	0	45.6	43	67.1	140	133	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	27	18	24	8	0.676	-0.102	3.937	0.01	0.007	0	45.2	42.6	61.9	140	133	0	35	34
2015	7	27	18	34	8	0.709	-0.062	3.937	0.013	0.01	0	45.6	43	67.1	140	133	0	34	33
2015	7	27	18	44	8	0.686	-0.102	3.937	0.013	0.01	0	45.2	42.6	67.9	140	132	0	35	33
2015	7	27	18	54	8	0.702	-0.085	3.937	0.01	0.007	0	46	43	67.1	141	133	0	34	33
2015	7	27	19	4	8	0.653	-0.066	3.94	0.016	0.013	0	45.2	42.6	67.1	140	133	0	35	34
2015	7	27	19	14	8	0.686	-0.092	3.94	0.01	0.007	0	46	42.6	67.1	141	133	0	34	34
2015	7	27	19	24	8	0.692	-0.069	3.94	0.016	0.013	0	45.6	43.4	67.5	141	133	0	35	32
2015	7	27	19	34	8	0.676	-0.102	3.94	0.013	0.01	0	45.6	43	67.1	140	133	0	34	33
2015	7	27	19	44	8	0.673	-0.082	3.94	0.01	0.007	0	45.6	42.6	67.5	140	133	0	34	34
2015	7	27	19	54	8	0.659	-0.092	3.94	0.01	0.007	0	46.4	43.4	67.1	142	134	0	34	33
2015	7	27	20	4	8	0.646	-0.082	3.94	0.01	0.007	0	46	43.9	67.1	141	134	0	34	32
2015	7	27	20	14	8	0.705	-0.079	3.94	0.01	0.007	0	46	43	66.2	141	133	0	34	33
2015	7	27	20	24	8	0.705	-0.089	3.94	0.01	0.007	0	46	43.4	65.8	142	134	0	35	33
2015	7	27	20	34	8	0.676	-0.102	3.94	0.01	0.007	0	47.3	44.3	64.5	144	136	0	34	33
2015	7	27	20	44	8	0.679	-0.092	3.94	0.01	0.007	0	46.9	43.9	65.4	143	136	0	34	34
2015	7	27	20	54	8	0.682	-0.079	3.94	0.013	0.01	0	46.9	43.4	65.8	143	135	0	34	34
2015	7	27	21	4	8	0.686	-0.085	3.94	0.01	0.007	0	46	43	66.7	141	133	0	34	33
2015	7	27	21	14	8	0.659	-0.085	3.944	0.01	0.007	0	46.9	43.9	67.1	143	135	0	34	33
2015	7	27	21	24	8	0.669	-0.092	3.944	0.01	0.007	0	46.9	43.9	66.7	143	135	0	34	33
2015	7	27	21	34	8	0.686	-0.131	3.944	0.013	0.01	0	46	43.4	66.7	142	135	0	35	34
2015	7	27	21	44	8	0.643	-0.072	3.947	0.013	0.01	0	47.3	44.3	65.4	144	136	0	34	33
2015	7	27	21	54	8	0.673	-0.072	3.944	0.01	0.007	0	46	43.4	65.4	142	134	0	35	33
2015	7	27	22	4	8	0.673	-0.056	3.947	0.013	0.01	0	46.4	43.4	65.8	142	134	0	34	33
2015	7	27	22	14	8	0.666	-0.072	3.95	0.013	0.01	0	45.6	43	66.7	141	133	0	35	33
2015	7	27	22	24	8	0.656	-0.085	3.95	0.016	0.013	0	46.9	43.9	65.8	144	135	0	35	33
2015	7	27	22	34	8	0.666	-0.085	3.95	0.013	0.01	0	46.9	44.3	66.7	143	135	0	34	32
2015	7	27	22	44	8	0.679	-0.102	3.947	0.01	0.007	0	46.4	43.9	64.9	143	135	0	35	33
2015	7	27	22	54	8	0.673	-0.052	3.95	0.01	0.007	0	46.9	43.9	65.8	143	135	0	34	33
2015	7	27	23	4	8	0.659	-0.102	3.953	0.01	0.007	0	47.3	44.3	65.8	144	136	0	34	33
2015	7	27	23	14	8	0.692	-0.095	3.95	0.016	0.016	0	47.3	43.9	64.5	144	135	0	34	33
2015	7	27	23	24	8	0.686	-0.098	3.95	0.013	0.01	0	46.4	43.9	63.6	142	135	0	34	33
2015	7	27	23	34	8	0.669	-0.066	3.95	0.013	0.01	0	46.4	43.9	58.9	142	135	0	34	33
2015	7	27	23	44	8	0.686	-0.085	3.953	0.01	0.007	0	47.3	44.3	60.2	144	136	0	34	33
2015	7	27	23	54	8	0.676	-0.095	3.953	0.013	0.01	0	46.9	43.4	60.6	143	135	0	34	34
2015	7	28	0	4	8	0.692	-0.089	3.953	0.013	0.01	0	46.9	44.3	56.8	143	135	0	34	32
2015	7	28	0	14	8	0.666	-0.102	3.953	0.016	0.016	0	46.9	43.4	56.3	143	135	0	34	34
2015	7	28	0	24	8	0.663	-0.059	3.953	0.01	0.007	0	46.9	43.9	63.6	143	135	0	34	33
2015	7	28	0	34	8	0.673	-0.105	3.953	0.01	0.007	0	46.4	43.4	57.2	142	134	0	34	33
2015	7	28	0	44	8	0.646	-0.052	3.953	0.01	0.007	0	47.3	44.3	55	144	136	0	34	33
2015	7	28	0	54	8	0.659	-0.085	3.953	0.01	0.007	0	46.9	44.3	53.8	144	136	0	35	33
2015	7	28	1	4	8	0.663	-0.069	3.953	0.01	0.007	0	46.9	44.7	52.9	143	136	0	34	32
2015	7	28	1	14	8	0.692	-0.052	3.953	0.01	0.007	0	46.9	43.4	57.2	143	135	0	34	34
2015	7	28	1	24	8	0.686	-0.075	3.957	0.01	0.007	0	46.4	43.4	56.3	142	134	0	34	33
2015	7	28	1	34	8	0.676	-0.085	3.953	0.01	0.007	0	46.9	43.9	57.2	143	135	0	34	33
2015	7	28	1	44	8	0.676	-0.089	3.953	0.01	0.007	0	46	43.4	60.6	142	134	0	35	33
2015	7	28	1	54	8	0.692	-0.098	3.957	0.016	0.016	0	46.4	43.4	58	142	134	0	34	33
2015	7	28	2	4	8	0.663	-0.108	3.957	0.013	0.01	0	46	43.9	61.5	142	135	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	28	2	14	8	0.659	-0.082	3.957	0.01	0.007	0	46.4	43.4	62.8	142	134	0	34	33
2015	7	28	2	24	8	0.65	-0.072	3.957	0.013	0.01	0	46	43.9	61.1	142	135	0	35	33
2015	7	28	2	34	8	0.689	-0.089	3.957	0.01	0.007	0	46	43.4	61.1	141	133	0	34	32
2015	7	28	2	44	8	0.656	-0.072	3.957	0.013	0.01	0	46.4	44.3	65.4	142	135	0	34	32
2015	7	28	2	54	8	0.673	-0.098	3.957	0.01	0.007	0	46.4	43.4	67.5	142	134	0	34	33
2015	7	28	3	4	8	0.656	-0.056	3.957	0.013	0.01	0	46.4	43.9	67.5	142	135	0	34	33
2015	7	28	3	14	8	0.659	-0.085	3.957	0.01	0.007	0	46	43.4	67.5	141	134	0	34	33
2015	7	28	3	24	8	0.669	-0.066	3.957	0.013	0.01	0	46.4	43.9	68.4	142	135	0	34	33
2015	7	28	3	34	8	0.705	-0.033	3.957	0.01	0.007	0	46.4	43.9	68.4	142	135	0	34	33
2015	7	28	3	44	8	0.689	-0.072	3.957	0.016	0.016	0	46.4	43	67.9	142	134	0	34	34
2015	7	28	3	54	8	0.673	-0.085	3.957	0.01	0.007	0	46.4	43.4	67.5	142	134	0	34	33
2015	7	28	4	4	8	0.669	-0.085	3.957	0.01	0.007	0	46	43.9	66.7	142	134	0	35	32
2015	7	28	4	14	8	0.676	-0.052	3.957	0.016	0.013	0	46	43.4	67.9	141	134	0	34	33
2015	7	28	4	24	8	0.663	-0.069	3.957	0.01	0.007	0	46.9	43.9	68.8	143	136	0	34	34
2015	7	28	4	34	8	0.696	-0.069	3.957	0.013	0.01	0	46.9	43.4	67.9	143	135	0	34	34
2015	7	28	4	44	8	0.682	-0.105	3.957	0.01	0.007	0	47.3	44.3	68.8	144	136	0	34	33
2015	7	28	4	54	8	0.676	-0.069	3.957	0.013	0.01	0	46.9	44.3	67.9	144	136	0	35	33
2015	7	28	5	4	8	0.689	-0.082	3.957	0.01	0.007	0	46.4	43.9	68.8	143	135	0	35	33
2015	7	28	5	14	8	0.673	-0.066	3.957	0.01	0.007	0	47.3	43.9	66.7	144	136	0	34	34
2015	7	28	5	24	8	0.686	-0.069	3.957	0.01	0.007	0	46	43.4	65.4	142	134	0	35	33
2015	7	28	5	34	8	0.732	-0.115	3.957	0.01	0.007	0	46.4	43.4	60.6	142	134	0	34	33
2015	7	28	5	44	8	0.64	-0.079	3.957	0.013	0.01	0	46.9	43.9	64.1	143	135	0	34	33
2015	7	28	5	54	8	0.682	-0.095	3.957	0.013	0.01	0	46.4	43.9	64.9	142	135	0	34	33
2015	7	28	6	4	8	0.686	-0.085	3.957	0.01	0.007	0	46	43.4	62.4	141	134	0	34	33
2015	7	28	6	14	8	0.699	-0.082	3.957	0.01	0.007	0	46	43.4	63.2	141	134	0	34	33
2015	7	28	6	24	8	0.669	-0.118	3.957	0.013	0.01	0	46	43	61.9	141	133	0	34	33
2015	7	28	6	34	8	0.689	-0.079	3.957	0.01	0.007	0	45.6	43	65.4	141	133	0	35	33
2015	7	28	6	44	8	0.656	-0.085	3.957	0.01	0.007	0	45.2	42.1	66.2	140	132	0	35	34
2015	7	28	6	54	8	0.686	-0.082	3.957	0.01	0.007	0	45.2	42.6	65.8	140	132	0	35	33
2015	7	28	7	4	8	0.689	-0.082	3.957	0.01	0.007	0	44.7	42.6	62.4	139	132	0	35	33
2015	7	28	7	14	8	0.725	-0.079	3.957	0.01	0.007	0	44.7	42.6	53.8	139	132	0	35	33
2015	7	28	7	24	8	0.702	-0.092	3.957	0.01	0.007	0	45.6	43	52.9	141	133	0	35	33
2015	7	28	7	34	8	0.696	-0.059	3.957	0.01	0.007	0	45.6	43	53.3	141	134	0	35	34
2015	7	28	7	44	8	0.676	-0.085	3.953	0.013	0.01	0	46.4	43.4	51.2	142	134	0	34	33
2015	7	28	7	54	8	0.712	-0.075	3.957	0.013	0.01	0	46.4	44.3	50.7	143	136	0	35	33
2015	7	28	8	4	8	0.673	-0.072	3.953	0.013	0.01	0	47.3	44.3	49.5	144	136	0	34	33
2015	7	28	8	14	8	0.653	-0.072	3.953	0.01	0.007	0	46.9	43.9	51.2	143	135	0	34	33
2015	7	28	8	24	8	0.689	-0.056	3.953	0.01	0.007	0	47.3	43.9	49.9	144	136	0	34	34
2015	7	28	8	34	8	0.689	-0.066	3.957	0.013	0.01	0	46.9	44.3	51.6	143	136	0	34	33
2015	7	28	8	44	8	0.689	-0.102	3.957	0.01	0.007	0	46.4	43.9	52.9	142	135	0	34	33
2015	7	28	8	54	8	0.673	-0.082	3.953	0.01	0.007	0	46.9	43.9	51.2	143	135	0	34	33
2015	7	28	9	4	8	0.712	-0.033	3.953	0.013	0.01	0	46.4	43.9	51.2	143	135	0	35	33
2015	7	28	9	14	8	0.689	-0.082	3.953	0.013	0.01	0	46	43.4	51.6	142	134	0	35	33
2015	7	28	9	24	8	0.686	-0.085	3.953	0.016	0.016	0	46	43.9	51.2	142	135	0	35	33
2015	7	28	9	34	8	0.682	-0.102	3.953	0.01	0.007	0	46.4	43.9	51.2	142	135	0	34	33
2015	7	28	9	44	8	0.659	-0.085	3.95	0.01	0.007	0	46.9	43.9	52	143	135	0	34	33
2015	7	28	9	54	8	0.679	-0.098	3.953	0.01	0.007	0	46	43.9	52.5	142	135	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	28	10	4	8	0.676	-0.085	3.95	0.013	0.01	0	46	43.9	52	142	135	0	35	33
2015	7	28	10	14	8	0.692	-0.062	3.953	0.01	0.007	0	46	43	53.8	142	134	0	35	34
2015	7	28	10	24	8	0.682	-0.095	3.95	0.013	0.01	0	46	43.9	56.8	142	135	0	35	33
2015	7	28	10	34	8	0.682	-0.095	3.95	0.01	0.007	0	46	43.4	53.8	141	135	0	34	34
2015	7	28	10	44	8	0.682	-0.052	3.947	0.01	0.007	0	46.9	43.9	60.6	143	135	0	34	33
2015	7	28	10	54	8	0.673	-0.118	3.944	0.013	0.01	0	46	43.4	59.8	141	134	0	34	33
2015	7	28	11	4	8	0.646	-0.092	3.94	0.01	0.007	0	46.4	44.3	60.6	142	135	0	34	32
2015	7	28	11	14	8	0.686	-0.098	3.94	0.01	0.007	0	46	43.4	62.4	141	134	0	34	33
2015	7	28	11	24	8	0.689	-0.043	3.937	0.013	0.01	0	45.6	43.4	65.4	141	134	0	35	33
2015	7	28	11	34	8	0.673	-0.082	3.937	0.01	0.007	0	46	43.9	63.6	142	135	0	35	33
2015	7	28	11	44	8	0.682	-0.066	3.937	0.01	0.007	0	46	43.4	63.2	141	134	0	34	33
2015	7	28	11	54	8	0.636	-0.092	3.937	0.01	0.007	0	46	43.4	65.8	141	134	0	34	33
2015	7	28	12	4	8	0.692	-0.089	3.934	0.01	0.007	0	45.6	43	66.7	140	133	0	34	33
2015	7	28	12	14	8	0.689	-0.059	3.934	0.013	0.01	0	46.4	44.7	65.4	142	136	0	34	32
2015	7	28	12	24	8	0.666	-0.072	3.934	0.01	0.007	0	46	43.9	59.8	142	135	0	35	33
2015	7	28	12	34	8	0.689	-0.125	3.934	0.013	0.01	0	45.6	43.4	65.4	140	134	0	34	33
2015	7	28	12	44	8	0.679	-0.154	3.934	0.01	0.007	0	44.7	42.1	56.3	138	131	0	34	33
2015	7	28	12	54	8	0.673	-0.141	3.934	0.016	0.013	0	44.7	41.7	53.3	138	130	0	34	33
2015	7	28	13	4	8	0.705	-0.105	3.93	0.01	0.007	0	45.2	42.6	69.2	139	132	0	34	33
2015	7	28	13	14	8	0.679	-0.108	3.934	0.013	0.01	0	46	43.4	69.2	141	134	0	34	33
2015	7	28	13	24	8	0.689	-0.102	3.934	0.013	0.01	0	45.2	42.6	59.8	140	133	0	35	34
2015	7	28	13	34	8	0.666	-0.161	3.93	0.013	0.01	0	44.7	41.7	61.5	138	130	0	34	33
2015	7	28	13	44	8	0.705	-0.102	3.93	0.016	0.013	0	44.7	43	62.4	139	132	0	35	32
2015	7	28	13	54	8	0.663	-0.135	3.93	0.013	0.01	0	45.2	42.6	58.9	139	132	0	34	33
2015	7	28	14	4	8	0.696	-0.118	3.93	0.01	0.007	0	46	43.4	69.2	141	134	0	34	33
2015	7	28	14	14	8	0.689	-0.151	3.93	0.01	0.007	0	45.2	42.1	54.2	140	132	0	35	34
2015	7	28	14	24	8	0.692	-0.128	3.93	0.01	0.007	0	45.2	42.1	52.9	139	132	0	34	34
2015	7	28	14	34	8	0.702	-0.085	3.93	0.013	0.01	0	44.7	43	56.8	139	132	0	35	32
2015	7	28	14	44	8	0.656	-0.161	3.927	0.01	0.007	0	44.7	41.7	56.3	138	131	0	34	34
2015	7	28	14	54	8	0.705	-0.128	3.927	0.01	0.007	0	45.2	42.6	64.9	139	132	0	34	33
2015	7	28	15	4	8	0.692	-0.128	3.927	0.01	0.007	0	44.7	42.1	61.5	138	131	0	34	33
2015	7	28	15	14	8	0.712	-0.098	3.927	0.01	0.007	0	46	43	67.1	140	133	0	33	33
2015	7	28	15	24	8	0.676	-0.102	3.927	0.013	0.01	0	45.6	43	70.5	140	133	0	34	33
2015	7	28	15	34	8	0.656	-0.118	3.927	0.013	0.01	0	44.3	42.1	55.9	138	131	0	35	33
2015	7	28	15	44	8	0.682	-0.121	3.927	0.016	0.013	0	45.2	42.6	68.8	139	132	0	34	33
2015	7	28	15	54	8	0.653	-0.115	3.927	0.01	0.007	0	45.2	42.6	61.1	139	132	0	34	33
2015	7	28	16	4	8	0.679	-0.108	3.927	0.013	0.01	0	45.2	43	71.4	139	132	0	34	32
2015	7	28	16	14	8	0.689	-0.092	3.927	0.01	0.007	0	45.2	42.6	62.4	139	132	0	34	33
2015	7	28	16	24	8	0.659	-0.095	3.927	0.016	0.016	0	45.6	43.4	71	140	134	0	34	33
2015	7	28	16	34	8	0.705	-0.105	3.927	0.013	0.01	0	45.6	43.4	70.1	140	134	0	34	33
2015	7	28	16	44	8	0.712	-0.131	3.924	0.013	0.01	0	44.7	42.1	63.6	138	131	0	34	33
2015	7	28	16	54	8	0.719	-0.098	3.924	0.01	0.007	0	45.2	42.6	61.9	139	132	0	34	33
2015	7	28	17	4	8	0.689	-0.118	3.927	0.01	0.007	0	45.6	43.4	71.8	140	134	0	34	33
2015	7	28	17	14	8	0.705	-0.135	3.924	0.01	0.007	0	44.3	42.1	69.2	138	131	0	35	33
2015	7	28	17	24	8	0.699	-0.105	3.924	0.01	0.007	0	45.2	43.4	71.4	139	133	0	34	32
2015	7	28	17	34	8	0.689	-0.075	3.924	0.016	0.013	0	45.2	43	71.8	140	133	0	35	33
2015	7	28	17	44	8	0.709	-0.089	3.924	0.01	0.007	0	46	43.4	67.5	141	134	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	28	17	54	8	0.676	-0.095	3.924	0.01	0.007	0	45.2	43	62.4	139	133	0	34	33
2015	7	28	18	4	8	0.673	-0.085	3.924	0.013	0.01	0	45.6	43	72.2	140	133	0	34	33
2015	7	28	18	14	8	0.656	-0.108	3.924	0.01	0.007	0	46	43	71.8	141	134	0	34	34
2015	7	28	18	24	8	0.659	-0.069	3.924	0.01	0.007	0	46	43.9	71.4	141	134	0	34	32
2015	7	28	18	34	8	0.689	-0.089	3.924	0.016	0.013	0	45.6	43	71.4	140	133	0	34	33
2015	7	28	18	44	8	0.732	-0.098	3.924	0.013	0.01	0	45.6	43	71.8	140	133	0	34	33
2015	7	28	18	54	8	0.679	-0.092	3.927	0.016	0.013	0	45.6	43.4	71	140	134	0	34	33
2015	7	28	19	4	8	0.689	-0.075	3.924	0.016	0.013	0	45.6	43	71.4	140	133	0	34	33
2015	7	28	19	14	8	0.696	-0.092	3.924	0.01	0.007	0	46.4	43.4	71	142	133	0	34	32
2015	7	28	19	24	8	0.65	-0.072	3.927	0.01	0.007	0	46	43	70.5	142	133	0	35	33
2015	7	28	19	34	8	0.656	-0.069	3.927	0.013	0.01	0	46.4	43	71	142	134	0	34	34
2015	7	28	19	44	8	0.673	-0.079	3.927	0.016	0.013	0	46.9	43.4	70.5	143	134	0	34	33
2015	7	28	19	54	8	0.709	-0.102	3.927	0.01	0.007	0	46	43	71.4	141	133	0	34	33
2015	7	28	20	4	8	0.666	-0.079	3.927	0.01	0.007	0	46.4	43.9	70.1	142	134	0	34	32
2015	7	28	20	14	8	0.623	-0.102	3.927	0.016	0.013	0	46.4	43.4	71.4	143	135	0	35	34
2015	7	28	20	24	8	0.669	-0.085	3.927	0.013	0.01	0	46.9	43.9	71.4	143	135	0	34	33
2015	7	28	20	34	8	0.679	-0.069	3.927	0.01	0.007	0	46.9	43.9	70.1	143	135	0	34	33
2015	7	28	20	44	8	0.676	-0.075	3.927	0.01	0.007	0	47.3	44.7	70.1	144	137	0	34	33
2015	7	28	20	54	8	0.65	-0.046	3.927	0.01	0.007	0	48.2	44.7	70.1	146	138	0	34	34
2015	7	28	21	4	8	0.666	-0.079	3.927	0.01	0.007	0	48.2	44.7	70.5	146	137	0	34	33
2015	7	28	21	14	8	0.656	-0.056	3.927	0.013	0.01	0	47.7	45.2	69.7	145	137	0	34	32
2015	7	28	21	24	8	0.669	-0.069	3.927	0.013	0.01	0	47.3	44.3	70.5	144	136	0	34	33
2015	7	28	21	34	8	0.673	-0.102	3.927	0.013	0.01	0	46.9	44.7	71	144	137	0	35	33
2015	7	28	21	44	8	0.666	-0.112	3.927	0.01	0.007	0	46.9	43.9	71	144	135	0	35	33
2015	7	28	21	54	8	0.656	-0.062	3.927	0.013	0.01	0	47.3	43.9	70.1	144	136	0	34	34
2015	7	28	22	4	8	0.656	-0.062	3.927	0.016	0.016	0	47.3	44.3	69.7	144	136	0	34	33
2015	7	28	22	14	8	0.692	-0.066	3.93	0.013	0.01	0	46.4	43.9	70.5	143	135	0	35	33
2015	7	28	22	24	8	0.676	-0.085	3.927	0.013	0.01	0	47.3	44.3	71	144	136	0	34	33
2015	7	28	22	34	8	0.673	-0.089	3.93	0.01	0.007	0	47.3	43.4	70.5	144	135	0	34	34
2015	7	28	22	44	8	0.696	-0.102	3.93	0.013	0.01	0	47.3	44.3	70.5	144	136	0	34	33
2015	7	28	22	54	8	0.712	-0.075	3.93	0.013	0.01	0	46.9	44.3	70.1	143	136	0	34	33
2015	7	28	23	4	8	0.669	-0.075	3.93	0.01	0.007	0	47.7	44.7	67.1	145	137	0	34	33
2015	7	28	23	14	8	0.682	-0.095	3.93	0.016	0.013	0	47.3	44.7	70.1	144	136	0	34	32
2015	7	28	23	24	8	0.666	-0.085	3.93	0.013	0.01	0	46.9	43.9	69.7	143	135	0	34	33
2015	7	28	23	34	8	0.669	-0.098	3.93	0.013	0.01	0	46.4	43.9	71	143	135	0	35	33
2015	7	28	23	44	8	0.679	-0.075	3.93	0.01	0.007	0	46.9	43.9	70.5	143	136	0	34	34
2015	7	28	23	54	8	0.682	-0.095	3.93	0.013	0.01	0	46.9	43.9	69.7	143	135	0	34	33
2015	7	29	0	4	8	0.702	-0.085	3.93	0.01	0.007	0	47.3	44.7	68.8	145	137	0	35	33
2015	7	29	0	14	8	0.692	-0.089	3.93	0.01	0.007	0	46.9	43.9	69.7	143	135	0	34	33
2015	7	29	0	24	8	0.656	-0.085	3.93	0.01	0.007	0	46.9	44.7	69.2	144	136	0	35	32
2015	7	29	0	34	8	0.682	-0.052	3.93	0.013	0.01	0	46.9	44.3	69.2	143	136	0	34	33
2015	7	29	0	44	8	0.659	-0.115	3.93	0.016	0.016	0	46.4	43.4	65.8	142	134	0	34	33
2015	7	29	0	54	8	0.699	-0.079	3.93	0.013	0.01	0	46.9	43.4	69.7	143	135	0	34	34
2015	7	29	1	4	8	0.719	-0.098	3.93	0.016	0.013	0	46.4	43.9	69.7	143	135	0	35	33
2015	7	29	1	14	8	0.656	-0.112	3.93	0.01	0.007	0	46.9	43.9	69.2	143	135	0	34	33
2015	7	29	1	24	8	0.643	-0.069	3.93	0.013	0.01	0	46.4	44.3	69.7	143	136	0	35	33
2015	7	29	1	34	8	0.666	-0.089	3.934	0.01	0.007	0	46	43.9	69.7	142	135	0	35	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	29	1	44	8	0.676	-0.072	3.93	0.01	0.007	0	47.3	44.3	69.2	144	136	0	34	33
2015	7	29	1	54	8	0.679	-0.085	3.934	0.016	0.013	0	46	43	69.2	142	134	0	35	34
2015	7	29	2	4	8	0.669	-0.066	3.934	0.01	0.007	0	46.9	43.9	69.2	143	135	0	34	33
2015	7	29	2	14	8	0.689	-0.059	3.934	0.01	0.007	0	47.3	43.9	69.2	144	135	0	34	33
2015	7	29	2	24	8	0.666	-0.062	3.934	0.013	0.01	0	47.3	43.9	68.8	144	135	0	34	33
2015	7	29	2	34	8	0.643	-0.089	3.934	0.013	0.01	0	47.3	44.3	68.8	145	136	0	35	33
2015	7	29	2	44	8	0.673	-0.082	3.934	0.013	0.01	0	47.3	44.7	68.8	145	136	0	35	32
2015	7	29	2	54	8	0.699	-0.072	3.934	0.013	0.01	0	46.9	43.9	68.4	143	135	0	34	33
2015	7	29	3	4	8	0.636	-0.059	3.934	0.01	0.007	0	47.3	43.9	68.4	144	136	0	34	34
2015	7	29	3	14	8	0.682	-0.082	3.934	0.013	0.01	0	47.3	43.9	67.1	143	135	0	33	33
2015	7	29	3	24	8	0.689	-0.059	3.934	0.01	0.007	0	47.3	43.9	68.4	144	135	0	34	33
2015	7	29	3	34	8	0.673	-0.056	3.934	0.013	0.01	0	48.2	44.3	66.7	146	137	0	34	34
2015	7	29	3	44	8	0.689	-0.098	3.934	0.01	0.007	0	46.9	43.9	67.5	143	135	0	34	33
2015	7	29	3	54	8	0.709	-0.082	3.934	0.013	0.01	0	47.7	44.7	61.9	145	137	0	34	33
2015	7	29	4	4	8	0.673	-0.066	3.934	0.013	0.01	0	47.7	44.7	67.5	145	137	0	34	33
2015	7	29	4	14	8	0.669	-0.092	3.934	0.01	0.007	0	47.7	44.3	67.5	145	136	0	34	33
2015	7	29	4	24	8	0.643	-0.072	3.934	0.013	0.01	0	47.7	44.7	66.7	145	137	0	34	33
2015	7	29	4	34	8	0.666	-0.102	3.934	0.013	0.01	0	47.3	43.9	67.1	144	136	0	34	34
2015	7	29	4	44	8	0.673	-0.098	3.934	0.01	0.007	0	47.7	44.7	65.8	145	137	0	34	33
2015	7	29	4	54	8	0.669	-0.082	3.934	0.016	0.013	0	47.7	43.9	64.9	145	136	0	34	34
2015	7	29	5	4	8	0.699	-0.082	3.934	0.013	0.01	0	47.7	44.7	66.2	145	137	0	34	33
2015	7	29	5	14	8	0.663	-0.059	3.934	0.01	0.007	0	47.3	44.3	66.7	144	136	0	34	33
2015	7	29	5	24	8	0.689	-0.092	3.934	0.016	0.013	0	46.9	44.3	66.7	144	136	0	35	33
2015	7	29	5	34	8	0.679	-0.043	3.937	0.016	0.016	0	47.3	44.3	66.7	144	136	0	34	33
2015	7	29	5	44	8	0.673	-0.102	3.937	0.01	0.007	0	46.4	43.9	65.8	143	135	0	35	33
2015	7	29	5	54	8	0.696	-0.108	3.937	0.013	0.01	0	46.9	43	65.8	143	134	0	34	34
2015	7	29	6	4	8	0.676	-0.062	3.937	0.01	0.007	0	46.4	43.4	66.2	143	134	0	35	33
2015	7	29	6	14	8	0.659	-0.069	3.94	0.01	0.007	0	46.4	43.9	65.8	143	135	0	35	33
2015	7	29	6	24	8	0.702	-0.112	3.94	0.016	0.013	0	46	43.4	66.2	142	134	0	35	33
2015	7	29	6	34	8	0.673	-0.102	3.944	0.01	0.007	0	45.6	42.6	66.2	141	133	0	35	34
2015	7	29	6	44	8	0.656	-0.082	3.944	0.01	0.007	0	46	43	66.2	142	133	0	35	33
2015	7	29	6	54	8	0.712	-0.092	3.944	0.01	0.007	0	46	43	67.1	141	132	0	34	32
2015	7	29	7	4	8	0.673	-0.098	3.947	0.01	0.007	0	46	42.6	67.1	141	133	0	34	34
2015	7	29	7	14	8	0.689	-0.052	3.947	0.016	0.013	0	46	43	67.5	141	133	0	34	33
2015	7	29	7	24	8	0.692	-0.102	3.947	0.01	0.007	0	45.6	43	66.7	141	133	0	35	33
2015	7	29	7	34	8	0.669	-0.105	3.947	0.01	0.007	0	45.6	42.6	66.7	140	132	0	34	33
2015	7	29	7	44	8	0.686	-0.089	3.944	0.013	0.01	0	46	43.4	66.7	142	134	0	35	33
2015	7	29	7	54	8	0.669	-0.072	3.944	0.01	0.007	0	46	43	66.2	141	133	0	34	33
2015	7	29	8	4	8	0.666	-0.056	3.944	0.013	0.01	0	46.4	43	66.2	142	134	0	34	34
2015	7	29	8	14	8	0.653	-0.092	3.94	0.01	0.007	0	46	43	66.7	141	133	0	34	33
2015	7	29	8	24	8	0.686	-0.069	3.94	0.013	0.01	0	46	43	65.8	141	133	0	34	33
2015	7	29	8	34	8	0.679	-0.092	3.94	0.01	0.007	0	46	43	64.1	141	133	0	34	33
2015	7	29	8	44	8	0.669	-0.089	3.937	0.01	0.007	0	46	43	66.7	141	133	0	34	33
2015	7	29	8	54	8	0.669	-0.102	3.934	0.01	0.007	0	46	43.4	65.8	142	134	0	35	33
2015	7	29	9	4	8	0.676	-0.079	3.934	0.013	0.01	0	46	43	66.2	142	134	0	35	34
2015	7	29	9	14	8	0.696	-0.102	3.934	0.01	0.007	0	46	43.4	67.5	142	134	0	35	33
2015	7	29	9	24	8	0.686	-0.075	3.934	0.013	0.01	0	46	43.9	67.1	142	134	0	35	32

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	29	9	34	8	0.689	-0.108	3.934	0.013	0.01	0	46	43	66.2	141	133	0	34	33
2015	7	29	9	44	8	0.692	-0.112	3.934	0.01	0.007	0	46	43	65.8	142	134	0	35	34
2015	7	29	9	54	8	0.689	-0.098	3.934	0.013	0.01	0	46.4	43.4	67.9	142	134	0	34	33
2015	7	29	10	4	8	0.676	-0.095	3.934	0.016	0.016	0	46	43.4	67.5	142	134	0	35	33
2015	7	29	10	14	8	0.686	-0.102	3.934	0.013	0.01	0	46	43.4	67.5	142	134	0	35	33
2015	7	29	10	24	8	0.673	-0.085	3.93	0.01	0.007	0	46.4	43.4	67.5	142	134	0	34	33
2015	7	29	10	34	8	0.686	-0.095	3.934	0.013	0.01	0	46	43.4	62.8	141	134	0	34	33
2015	7	29	10	44	8	0.669	-0.105	3.93	0.01	0.007	0	45.2	42.1	69.2	139	131	0	34	33
2015	7	29	10	54	8	0.692	-0.105	3.93	0.016	0.013	0	45.6	42.6	68.4	140	132	0	34	33
2015	7	29	11	4	8	0.699	-0.118	3.93	0.016	0.013	0	44.7	42.1	69.2	139	131	0	35	33
2015	7	29	11	14	8	0.712	-0.118	3.93	0.01	0.007	0	45.6	43.4	65.8	141	134	0	35	33
2015	7	29	11	24	8	0.682	-0.167	3.93	0.01	0.007	0	45.2	41.7	65.4	139	130	0	34	33
2015	7	29	11	34	8	0.676	-0.131	3.93	0.013	0.01	0	44.3	42.1	69.7	138	131	0	35	33
2015	7	29	11	44	8	0.689	-0.138	3.927	0.01	0.007	0	45.2	42.1	70.5	139	131	0	34	33
2015	7	29	11	54	8	0.712	-0.085	3.927	0.013	0.01	0	45.6	42.6	68.4	141	133	0	35	34
2015	7	29	12	4	8	0.669	-0.102	3.927	0.016	0.013	0	46	42.6	67.5	141	133	0	34	34
2015	7	29	12	14	8	0.689	-0.144	3.927	0.016	0.013	0	45.2	42.6	68.8	139	132	0	34	33
2015	7	29	12	24	8	0.653	-0.075	3.927	0.016	0.013	0	45.6	42.1	69.7	140	132	0	34	34
2015	7	29	12	34	8	0.686	-0.131	3.927	0.01	0.007	0	44.7	41.3	71	138	130	0	34	34
2015	7	29	12	44	8	0.669	-0.085	3.927	0.013	0.01	0	46	43.4	58.5	141	134	0	34	33
2015	7	29	12	54	8	0.673	-0.128	3.927	0.013	0.01	0	44.7	42.1	60.2	138	130	0	34	32
2015	7	29	13	4	8	0.686	-0.18	3.927	0.01	0.007	0	44.7	41.7	64.5	138	130	0	34	33
2015	7	29	13	14	8	0.666	-0.105	3.927	0.01	0.007	0	46	43	56.3	141	133	0	34	33
2015	7	29	13	24	8	0.682	-0.161	3.927	0.01	0.007	0	45.2	42.1	61.9	139	131	0	34	33
2015	7	29	13	34	8	0.656	-0.154	3.927	0.01	0.007	0	44.3	40.9	56.3	138	129	0	35	34
2015	7	29	13	44	8	0.669	-0.18	3.927	0.01	0.007	0	44.7	41.7	53.3	138	130	0	34	33
2015	7	29	13	54	8	0.673	-0.138	3.924	0.01	0.007	0	45.2	42.6	55	140	132	0	35	33
2015	7	29	14	4	8	0.656	-0.118	3.927	0.01	0.007	0	45.2	42.1	55	139	131	0	34	33
2015	7	29	14	14	8	0.653	-0.128	3.924	0.013	0.01	0	45.2	42.1	59.8	139	131	0	34	33
2015	7	29	14	24	8	0.653	-0.154	3.924	0.01	0.007	0	44.7	41.7	59.3	138	130	0	34	33
2015	7	29	14	34	8	0.699	-0.138	3.924	0.016	0.013	0	45.2	42.6	60.6	140	133	0	35	34
2015	7	29	14	44	8	0.679	-0.141	3.924	0.013	0.01	0	45.2	42.6	60.6	139	132	0	34	33
2015	7	29	14	54	8	0.673	-0.131	3.924	0.013	0.01	0	45.2	42.1	54.6	139	131	0	34	33
2015	7	29	15	4	8	0.692	-0.144	3.924	0.013	0.01	0	44.7	42.6	60.6	139	132	0	35	33
2015	7	29	15	14	8	0.702	-0.102	3.924	0.013	0.01	0	45.2	42.6	71	139	132	0	34	33
2015	7	29	15	24	8	0.673	-0.089	3.924	0.01	0.007	0	44.3	41.7	54.6	138	130	0	35	33
2015	7	29	15	34	8	0.689	-0.135	3.921	0.013	0.01	0	43.9	41.7	59.8	137	130	0	35	33
2015	7	29	15	44	8	0.673	-0.154	3.921	0.013	0.01	0	44.7	42.1	57.2	138	131	0	34	33
2015	7	29	15	54	8	0.653	-0.121	3.921	0.01	0.007	0	45.2	42.1	71.4	139	131	0	34	33
2015	7	29	16	4	8	0.653	-0.128	3.921	0.013	0.01	0	45.2	42.6	53.8	139	132	0	34	33
2015	7	29	16	14	8	0.686	-0.141	3.921	0.01	0.007	0	45.2	42.1	56.3	139	131	0	34	33
2015	7	29	16	24	8	0.719	-0.108	3.921	0.013	0.01	0	45.2	42.1	58.5	139	131	0	34	33
2015	7	29	16	34	8	0.666	-0.105	3.914	0.01	0.007	0	48.2	44.7	40.4	146	136	0	34	32
2015	7	29	16	44	8	0.627	-0.144	3.917	0.01	0.007	0	52.5	49	48.2	157	147	0	35	33
2015	7	29	16	54	8	0.692	-0.095	3.917	0.016	0.013	0	51.6	48.6	48.2	154	146	0	34	33
2015	7	29	17	4	8	0.722	-0.115	3.914	0.016	0.013	0	51.2	48.2	52	153	145	0	34	33
2015	7	29	17	14	8	0.689	-0.115	3.921	0.01	0.007	0	45.6	43	59.8	140	133	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	29	17	24	8	0.689	-0.138	3.921	0.013	0.01	0	45.2	42.6	58	139	132	0	34	33
2015	7	29	17	34	8	0.705	-0.115	3.917	0.01	0.007	0	45.2	42.1	53.8	139	131	0	34	33
2015	7	29	17	44	8	0.699	-0.112	3.921	0.01	0.007	0	45.6	42.1	65.8	139	131	0	33	33
2015	7	29	17	54	8	0.682	-0.118	3.917	0.016	0.016	0	45.2	42.1	58.5	139	132	0	34	34
2015	7	29	18	4	8	0.699	-0.131	3.917	0.01	0.007	0	44.7	42.1	61.9	138	131	0	34	33
2015	7	29	18	14	8	0.689	-0.066	3.921	0.01	0.007	0	45.2	42.6	61.1	139	132	0	34	33
2015	7	29	18	24	8	0.705	-0.118	3.921	0.016	0.013	0	45.2	42.1	58.9	139	131	0	34	33
2015	7	29	18	34	8	0.699	-0.098	3.917	0.013	0.01	0	45.2	42.1	64.1	139	131	0	34	33
2015	7	29	18	44	8	0.686	-0.108	3.917	0.013	0.01	0	45.2	42.6	48.6	139	132	0	34	33
2015	7	29	18	54	8	0.702	-0.102	3.917	0.01	0.007	0	45.2	43	49.9	140	133	0	35	33
2015	7	29	19	4	8	0.689	-0.079	3.917	0.01	0.007	0	46	43	50.3	141	133	0	34	33
2015	7	29	19	14	8	0.673	-0.115	3.921	0.01	0.007	0	44.7	42.6	60.6	139	132	0	35	33
2015	7	29	19	24	8	0.699	-0.121	3.921	0.013	0.01	0	45.2	42.6	57.2	139	132	0	34	33
2015	7	29	19	34	8	0.686	-0.092	3.921	0.013	0.01	0	45.2	42.1	61.1	139	132	0	34	34
2015	7	29	19	44	8	0.682	-0.062	3.921	0.01	0.007	0	45.6	42.6	59.3	140	132	0	34	33
2015	7	29	19	54	8	0.673	-0.128	3.921	0.01	0.007	0	45.6	43.4	62.8	141	133	0	35	32
2015	7	29	20	4	8	0.686	-0.102	3.921	0.013	0.01	0	45.2	43.4	62.8	140	133	0	35	32
2015	7	29	20	14	8	0.663	-0.118	3.921	0.01	0.007	0	46.9	43.9	70.1	143	135	0	34	33
2015	7	29	20	24	8	0.656	-0.066	3.921	0.01	0.007	0	47.3	44.3	63.6	144	136	0	34	33
2015	7	29	20	34	8	0.715	-0.072	3.921	0.01	0.007	0	46.9	43.9	69.7	143	135	0	34	33
2015	7	29	20	44	8	0.666	-0.105	3.921	0.01	0.007	0	46.9	43.9	69.2	143	135	0	34	33
2015	7	29	20	54	8	0.673	-0.089	3.921	0.013	0.01	0	47.3	44.3	56.8	144	136	0	34	33
2015	7	29	21	4	8	0.673	-0.092	3.924	0.01	0.007	0	47.3	44.3	50.3	144	136	0	34	33
2015	7	29	21	14	8	0.663	-0.075	3.921	0.013	0.01	0	47.3	44.3	49	144	136	0	34	33
2015	7	29	21	24	8	0.656	-0.082	3.921	0.013	0.01	0	48.2	45.2	46.4	146	138	0	34	33
2015	7	29	21	34	8	0.669	-0.069	3.921	0.016	0.013	0	48.6	45.2	48.6	147	138	0	34	33
2015	7	29	21	44	8	0.669	-0.085	3.924	0.01	0.007	0	48.2	45.2	52	146	138	0	34	33
2015	7	29	21	54	8	0.692	-0.102	3.921	0.013	0.01	0	47.3	44.3	49.9	144	136	0	34	33
2015	7	29	22	4	8	0.666	-0.066	3.921	0.013	0.01	0	47.7	44.7	49	145	137	0	34	33
2015	7	29	22	14	8	0.673	-0.072	3.924	0.01	0.007	0	48.6	45.2	48.6	147	138	0	34	33
2015	7	29	22	24	8	0.679	-0.052	3.921	0.01	0.007	0	48.6	45.2	50.3	146	138	0	33	33
2015	7	29	22	34	8	0.702	-0.069	3.924	0.01	0.007	0	47.7	45.2	49	146	137	0	35	32
2015	7	29	22	44	8	0.709	-0.075	3.924	0.013	0.01	0	48.2	44.3	49.9	145	137	0	33	34
2015	7	29	22	54	8	0.676	-0.105	3.924	0.013	0.01	0	46.4	43.9	53.3	143	135	0	35	33
2015	7	29	23	4	8	0.659	-0.085	3.927	0.013	0.01	0	47.3	44.7	51.6	145	137	0	35	33
2015	7	29	23	14	8	0.673	-0.098	3.927	0.01	0.007	0	46.9	43.9	55	143	135	0	34	33
2015	7	29	23	24	8	0.659	-0.069	3.927	0.01	0.007	0	47.3	43.9	57.6	144	136	0	34	34
2015	7	29	23	34	8	0.669	-0.085	3.924	0.01	0.007	0	45.6	43	50.3	141	134	0	35	34
2015	7	29	23	44	8	0.702	-0.102	3.927	0.013	0.01	0	46	43.4	55	142	134	0	35	33
2015	7	29	23	54	8	0.692	-0.092	3.927	0.013	0.01	0	46.4	43.4	58.5	142	134	0	34	33
2015	7	30	0	4	8	0.692	-0.112	3.927	0.016	0.013	0	46	43	55.9	141	133	0	34	33
2015	7	30	0	14	8	0.696	-0.092	3.927	0.01	0.007	0	46.9	43.4	54.6	143	135	0	34	34
2015	7	30	0	24	8	0.702	-0.102	3.927	0.01	0.007	0	46.4	43.4	65.4	142	134	0	34	33
2015	7	30	0	34	8	0.673	-0.079	3.927	0.01	0.007	0	46.4	43.9	70.5	142	135	0	34	33
2015	7	30	0	44	8	0.702	-0.085	3.927	0.01	0.007	0	47.3	43.9	66.7	144	136	0	34	34
2015	7	30	0	54	8	0.676	-0.082	3.927	0.01	0.007	0	47.7	44.7	62.4	146	137	0	35	33
2015	7	30	1	4	8	0.669	-0.098	3.93	0.01	0.007	0	47.3	44.3	57.6	143	136	0	33	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	30	1	14	8	0.659	-0.066	3.927	0.013	0.01	0	46.9	44.3	70.5	144	136	0	35	33
2015	7	30	1	24	8	0.712	-0.082	3.93	0.013	0.01	0	46.9	44.3	70.1	143	135	0	34	32
2015	7	30	1	34	8	0.676	-0.089	3.93	0.013	0.01	0	47.3	43.9	71.8	143	135	0	33	33
2015	7	30	1	44	8	0.686	-0.059	3.93	0.016	0.013	0	47.3	44.3	70.5	144	136	0	34	33
2015	7	30	1	54	8	0.692	-0.085	3.93	0.016	0.013	0	46.9	44.3	70.5	143	135	0	34	32
2015	7	30	2	4	8	0.702	-0.118	3.93	0.013	0.01	0	47.3	44.7	71	144	136	0	34	32
2015	7	30	2	14	8	0.689	-0.112	3.93	0.016	0.013	0	46.9	43.9	70.5	143	135	0	34	33
2015	7	30	2	24	8	0.696	-0.092	3.93	0.013	0.01	0	46.4	43.9	71.4	142	135	0	34	33
2015	7	30	2	34	8	0.692	-0.098	3.93	0.016	0.013	0	46.9	44.3	67.5	143	135	0	34	32
2015	7	30	2	44	8	0.682	-0.102	3.93	0.013	0.01	0	46.4	43.4	71.4	142	134	0	34	33
2015	7	30	2	54	8	0.676	-0.082	3.93	0.01	0.007	0	46.4	43.9	70.1	142	135	0	34	33
2015	7	30	3	4	8	0.676	-0.059	3.93	0.01	0.007	0	46.9	44.3	70.5	143	136	0	34	33
2015	7	30	3	14	8	0.692	-0.082	3.93	0.01	0.007	0	46.4	43.9	69.7	142	135	0	34	33
2015	7	30	3	24	8	0.689	-0.112	3.93	0.01	0.007	0	47.3	44.3	68.8	144	136	0	34	33
2015	7	30	3	34	8	0.699	-0.105	3.93	0.016	0.013	0	46.4	43.9	70.1	142	135	0	34	33
2015	7	30	3	44	8	0.676	-0.085	3.93	0.013	0.01	0	47.3	44.3	69.2	144	136	0	34	33
2015	7	30	3	54	8	0.676	-0.098	3.93	0.01	0.007	0	46.9	44.3	69.2	144	136	0	35	33
2015	7	30	4	4	8	0.699	-0.112	3.93	0.013	0.01	0	46.4	43.4	69.7	143	134	0	35	33
2015	7	30	4	14	8	0.709	-0.102	3.93	0.01	0.007	0	47.3	44.3	69.7	144	136	0	34	33
2015	7	30	4	24	8	0.696	-0.092	3.93	0.01	0.007	0	47.3	44.3	69.7	144	136	0	34	33
2015	7	30	4	34	8	0.646	-0.069	3.93	0.01	0.007	0	46.9	44.3	69.7	144	136	0	35	33
2015	7	30	4	44	8	0.692	-0.105	3.93	0.01	0.007	0	46.4	43.4	70.1	142	134	0	34	33
2015	7	30	4	54	8	0.676	-0.079	3.93	0.01	0.007	0	46.4	43	68.8	142	134	0	34	34
2015	7	30	5	4	8	0.653	-0.049	3.93	0.016	0.016	0	47.3	44.7	69.7	144	136	0	34	32
2015	7	30	5	14	8	0.673	-0.062	3.93	0.01	0.007	0	47.3	44.3	69.2	144	136	0	34	33
2015	7	30	5	24	8	0.666	-0.089	3.934	0.01	0.007	0	46.9	43.9	69.7	143	135	0	34	33
2015	7	30	5	34	8	0.679	-0.118	3.93	0.01	0.007	0	46.9	43.4	68.8	143	135	0	34	34
2015	7	30	5	44	8	0.686	-0.052	3.934	0.01	0.007	0	46.4	43.4	69.2	143	134	0	35	33
2015	7	30	5	54	8	0.673	-0.108	3.93	0.01	0.007	0	46.9	43.9	69.2	143	135	0	34	33
2015	7	30	6	4	8	0.673	-0.082	3.934	0.01	0.007	0	46.4	43.9	69.2	143	135	0	35	33
2015	7	30	6	14	8	0.673	-0.085	3.934	0.013	0.01	0	46.9	43.9	68.8	143	135	0	34	33
2015	7	30	6	24	8	0.676	-0.079	3.934	0.01	0.007	0	46.4	43.4	68.8	142	134	0	34	33
2015	7	30	6	34	8	0.696	-0.049	3.934	0.01	0.007	0	46.4	43.4	69.2	142	134	0	34	33
2015	7	30	6	44	8	0.686	-0.075	3.934	0.01	0.007	0	46.4	43.4	69.7	142	134	0	34	33
2015	7	30	6	54	8	0.676	-0.079	3.934	0.01	0.007	0	46	43.9	68.8	142	134	0	35	32
2015	7	30	7	4	8	0.673	-0.085	3.934	0.01	0.007	0	46.4	43.4	68.4	142	134	0	34	33
2015	7	30	7	14	8	0.676	-0.095	3.934	0.013	0.01	0	46.4	43	68.8	142	133	0	34	33
2015	7	30	7	24	8	0.696	-0.075	3.934	0.01	0.007	0	46	43	68.8	141	133	0	34	33
2015	7	30	7	34	8	0.692	-0.121	3.934	0.013	0.01	0	45.6	43	68.4	141	133	0	35	33
2015	7	30	7	44	8	0.692	-0.082	3.934	0.016	0.013	0	46	43	68.4	141	133	0	34	33
2015	7	30	7	54	8	0.696	-0.102	3.934	0.01	0.007	0	46	43.4	67.1	142	134	0	35	33
2015	7	30	8	4	8	0.689	-0.092	3.934	0.01	0.007	0	46	43	67.9	141	132	0	34	32
2015	7	30	8	14	8	0.689	-0.095	3.934	0.01	0.007	0	45.6	42.1	69.2	140	132	0	34	34
2015	7	30	8	24	8	0.663	-0.092	3.934	0.01	0.007	0	45.6	43	69.2	141	133	0	35	33
2015	7	30	8	34	8	0.682	-0.118	3.934	0.01	0.007	0	46	43	69.2	141	133	0	34	33
2015	7	30	8	44	8	0.692	-0.079	3.934	0.013	0.01	0	46.4	43.4	69.2	142	134	0	34	33
2015	7	30	8	54	8	0.699	-0.079	3.934	0.016	0.013	0	45.6	43	69.7	140	133	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	30	9	10	21	0.663	-0.098	3.934	0.01	0.007	0	46.4	43.4	69.2	142	134	0	34	33
2015	7	30	9	20	21	0.689	-0.089	3.934	0.01	0.007	0	46	43.4	69.7	141	134	0	34	33
2015	7	30	9	30	21	0.692	-0.082	3.934	0.01	0.007	0	46	43.4	69.2	141	134	0	34	33
2015	7	30	9	40	21	0.663	-0.085	3.934	0.013	0.01	0	46.4	43.4	69.2	141	134	0	33	33
2015	7	30	9	50	21	0.705	-0.112	3.934	0.01	0.007	0	46	43	69.2	141	133	0	34	33
2015	7	30	10	0	21	0.696	-0.085	3.934	0.013	0.01	0	46	43	68.4	140	133	0	33	33
2015	7	30	10	10	21	0.709	-0.135	3.934	0.013	0.01	0	44.7	42.6	58	139	132	0	35	33
2015	7	30	10	20	21	0.692	-0.095	3.934	0.01	0.007	0	45.6	42.6	59.8	140	132	0	34	33
2015	7	30	10	30	21	0.679	-0.118	3.934	0.013	0.01	0	45.6	43	69.7	140	133	0	34	33
2015	7	30	10	40	21	0.682	-0.128	3.934	0.01	0.007	0	45.6	43	70.1	140	133	0	34	33
2015	7	30	10	50	21	0.738	-0.121	3.934	0.013	0.01	0	45.6	43.4	70.1	141	134	0	35	33
2015	7	30	11	0	21	0.712	-0.085	3.934	0.01	0.007	0	46.4	43.4	69.2	142	134	0	34	33
2015	7	30	11	10	21	0.656	-0.131	3.934	0.013	0.01	0	45.6	43	70.5	140	133	0	34	33
2015	7	30	11	20	21	0.659	-0.089	3.934	0.01	0.007	0	47.3	44.3	69.7	143	136	0	33	33
2015	7	30	11	30	21	0.646	-0.141	3.934	0.016	0.013	0	46	43.4	69.7	141	134	0	34	33
2015	7	30	11	40	21	0.696	-0.135	3.934	0.01	0.007	0	45.6	42.6	69.7	140	133	0	34	34
2015	7	30	11	50	21	0.725	-0.148	3.93	0.01	0.007	0	45.6	43	63.6	140	133	0	34	33
2015	7	30	12	0	21	0.682	-0.121	3.934	0.013	0.01	0	46	43.4	64.9	141	134	0	34	33
2015	7	30	12	10	21	0.709	-0.105	3.93	0.013	0.01	0	45.6	43	64.1	140	133	0	34	33
2015	7	30	12	20	21	0.702	-0.125	3.93	0.01	0.007	0	45.6	43	68.4	140	133	0	34	33
2015	7	30	12	30	21	0.676	-0.118	3.93	0.013	0.01	0	45.2	42.1	65.8	139	132	0	34	34
2015	7	30	12	40	21	0.673	-0.154	3.93	0.013	0.01	0	45.2	42.6	68.4	139	132	0	34	33
2015	7	30	12	50	21	0.692	-0.102	3.93	0.013	0.01	0	45.2	42.6	68.4	140	132	0	35	33
2015	7	30	13	0	21	0.669	-0.125	3.93	0.01	0.007	0	45.6	42.6	66.2	139	132	0	33	33
2015	7	30	13	10	21	0.676	-0.105	3.93	0.01	0.007	0	46	43	65.4	140	133	0	33	33
2015	7	30	13	20	21	0.659	-0.112	3.93	0.013	0.01	0	45.6	43	57.2	140	133	0	34	33
2015	7	30	13	30	21	0.676	-0.144	3.93	0.01	0.007	0	45.2	42.6	68.4	139	132	0	34	33
2015	7	30	13	40	21	0.673	-0.105	3.93	0.01	0.007	0	45.2	42.1	67.1	139	132	0	34	34
2015	7	30	13	50	21	0.679	-0.131	3.93	0.013	0.01	0	45.6	42.6	59.8	140	133	0	34	34
2015	7	30	14	0	21	0.679	-0.131	3.93	0.01	0.007	0	44.7	42.6	67.5	138	131	0	34	32
2015	7	30	14	10	21	0.673	-0.115	3.93	0.01	0.007	0	45.2	42.6	65.4	139	132	0	34	33
2015	7	30	14	20	21	0.705	-0.102	3.93	0.016	0.013	0	45.6	43.4	70.1	140	134	0	34	33
2015	7	30	14	30	21	0.676	-0.135	3.93	0.01	0.007	0	45.6	43	70.1	140	133	0	34	33
2015	7	30	14	40	21	0.689	-0.089	3.93	0.016	0.013	0	46	43.4	71.4	141	134	0	34	33
2015	7	30	14	50	21	0.689	-0.128	3.93	0.01	0.007	0	44.3	42.1	71.8	138	131	0	35	33
2015	7	30	15	0	21	0.676	-0.089	3.93	0.013	0.01	0	46	43.9	71	142	135	0	35	33
2015	7	30	15	10	21	0.65	-0.069	3.93	0.01	0.007	0	46.4	43.9	70.5	142	135	0	34	33
2015	7	30	15	20	21	0.699	-0.072	3.93	0.01	0.007	0	46.4	44.3	64.9	142	136	0	34	33
2015	7	30	15	30	21	0.676	-0.089	3.93	0.01	0.007	0	46	43.4	67.5	141	134	0	34	33
2015	7	30	15	40	21	0.666	-0.135	3.93	0.013	0.01	0	45.2	43	55.9	139	132	0	34	32
2015	7	30	15	50	21	0.659	-0.085	3.93	0.01	0.007	0	47.3	44.3	49.5	144	136	0	34	33
2015	7	30	16	0	21	0.676	-0.102	3.927	0.013	0.01	0	49	46	46.4	149	140	0	35	33
2015	7	30	16	10	21	0.679	-0.069	3.93	0.01	0.007	0	50.7	47.3	58.9	152	143	0	34	33
2015	7	30	16	20	21	0.663	-0.062	3.93	0.013	0.01	0	50.7	47.7	61.1	152	144	0	34	33
2015	7	30	16	30	21	0.663	-0.092	3.93	0.01	0.007	0	50.3	47.3	67.1	151	143	0	34	33
2015	7	30	16	40	21	0.682	-0.052	3.93	0.013	0.01	0	49	46	64.5	148	140	0	34	33
2015	7	30	16	50	21	0.682	-0.079	3.93	0.01	0.007	0	49	45.6	66.2	148	139	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	30	17	0	21	0.666	-0.089	3.93	0.016	0.013	0	47.7	44.3	67.9	146	137	0	35	34
2015	7	30	17	10	21	0.686	-0.066	3.93	0.01	0.007	0	47.7	44.7	59.8	145	137	0	34	33
2015	7	30	17	20	21	0.679	-0.052	3.93	0.013	0.01	0	47.3	44.3	62.8	145	136	0	35	33
2015	7	30	17	30	21	0.679	-0.098	3.934	0.01	0.007	0	47.3	44.7	57.6	144	136	0	34	32
2015	7	30	17	40	21	0.676	-0.056	3.934	0.013	0.01	0	47.3	44.3	64.1	144	136	0	34	33
2015	7	30	17	50	21	0.686	-0.085	3.93	0.01	0.007	0	46.9	43.9	69.7	143	135	0	34	33
2015	7	30	18	0	21	0.669	-0.085	3.934	0.01	0.007	0	46.9	43.9	55.5	143	135	0	34	33
2015	7	30	18	10	21	0.692	-0.072	3.934	0.013	0.01	0	47.3	43.9	68.8	144	135	0	34	33
2015	7	30	18	20	21	0.676	-0.085	3.934	0.01	0.007	0	46.9	43.9	69.7	144	136	0	35	34
2015	7	30	18	30	21	0.692	-0.082	3.934	0.016	0.013	0	46.4	43.9	69.7	143	135	0	35	33
2015	7	30	18	40	21	0.702	-0.069	3.934	0.013	0.01	0	47.3	43.9	69.2	144	135	0	34	33
2015	7	30	18	50	21	0.689	-0.102	3.934	0.01	0.007	0	46.9	43.9	65.8	143	135	0	34	33
2015	7	30	19	0	21	0.686	-0.085	3.934	0.01	0.007	0	46.9	43.9	63.6	143	135	0	34	33
2015	7	30	19	10	21	0.673	-0.089	3.934	0.01	0.007	0	46.9	43.9	65.8	143	135	0	34	33
2015	7	30	19	20	21	0.669	-0.092	3.934	0.013	0.01	0	46.4	43.9	65.4	143	135	0	35	33
2015	7	30	19	30	21	0.673	-0.085	3.937	0.01	0.007	0	47.3	44.3	53.3	144	136	0	34	33
2015	7	30	19	40	21	0.659	-0.082	3.937	0.013	0.01	0	47.7	44.7	54.2	145	137	0	34	33
2015	7	30	19	50	21	0.666	-0.066	3.937	0.01	0.007	0	47.3	44.3	52.9	144	136	0	34	33
2015	7	30	20	0	21	0.692	-0.102	3.937	0.01	0.007	0	46.9	43.9	55	144	136	0	35	34
2015	7	30	20	10	21	0.646	-0.049	3.934	0.013	0.01	0	47.7	44.7	62.8	145	137	0	34	33
2015	7	30	20	20	21	0.692	-0.102	3.937	0.01	0.007	0	47.3	43.9	66.2	144	136	0	34	34
2015	7	30	20	30	21	0.679	-0.082	3.937	0.01	0.007	0	47.7	44.7	67.5	145	137	0	34	33
2015	7	30	20	40	21	0.659	-0.085	3.937	0.013	0.01	0	47.7	45.2	67.5	145	138	0	34	33
2015	7	30	20	50	21	0.705	-0.082	3.937	0.01	0.007	0	47.7	44.3	67.1	144	136	0	33	33
2015	7	30	21	0	21	0.669	-0.085	3.937	0.016	0.013	0	47.3	44.3	67.9	144	136	0	34	33
2015	7	30	21	10	21	0.702	-0.075	3.937	0.013	0.01	0	47.7	44.7	67.1	145	137	0	34	33
2015	7	30	21	20	21	0.682	-0.062	3.937	0.01	0.007	0	47.3	44.7	67.5	144	137	0	34	33
2015	7	30	21	30	21	0.673	-0.095	3.937	0.01	0.007	0	47.7	44.7	67.5	145	137	0	34	33
2015	7	30	21	40	21	0.682	-0.095	3.937	0.01	0.007	0	47.7	45.2	67.1	145	138	0	34	33
2015	7	30	21	50	21	0.659	-0.072	3.94	0.01	0.007	0	47.3	45.2	67.1	145	137	0	35	32
2015	7	30	22	0	21	0.686	-0.049	3.94	0.013	0.01	0	48.2	44.7	67.1	146	137	0	34	33
2015	7	30	22	10	21	0.673	-0.079	3.94	0.016	0.013	0	47.7	44.7	67.1	145	137	0	34	33
2015	7	30	22	20	21	0.692	-0.066	3.94	0.01	0.007	0	47.3	44.3	67.5	144	136	0	34	33
2015	7	30	22	30	21	0.686	-0.102	3.94	0.01	0.007	0	46.9	44.7	66.2	144	137	0	35	33
2015	7	30	22	40	21	0.673	-0.085	3.94	0.01	0.007	0	47.3	43.9	66.7	144	135	0	34	33
2015	7	30	22	50	21	0.663	-0.085	3.94	0.016	0.013	0	47.7	44.7	67.5	145	137	0	34	33
2015	7	30	23	0	21	0.673	-0.089	3.94	0.013	0.01	0	47.7	44.7	66.2	145	137	0	34	33
2015	7	30	23	10	21	0.699	-0.112	3.94	0.01	0.007	0	47.7	44.3	65.8	145	136	0	34	33
2015	7	30	23	20	21	0.696	-0.075	3.944	0.013	0.01	0	48.2	44.7	66.2	146	137	0	34	33
2015	7	30	23	30	21	0.676	-0.089	3.944	0.01	0.007	0	47.7	45.6	63.6	146	138	0	35	32
2015	7	30	23	40	21	0.666	-0.066	3.944	0.013	0.01	0	47.7	44.7	64.9	145	137	0	34	33
2015	7	30	23	50	21	0.659	-0.079	3.947	0.01	0.007	0	48.2	45.2	65.8	146	138	0	34	33
2015	7	31	0	0	21	0.676	-0.089	3.947	0.01	0.007	0	47.7	44.3	64.9	145	137	0	34	34
2015	7	31	0	10	21	0.686	-0.075	3.95	0.01	0.007	0	48.2	45.2	66.2	146	138	0	34	33
2015	7	31	0	20	21	0.696	-0.102	3.95	0.01	0.007	0	47.7	44.7	66.2	145	137	0	34	33
2015	7	31	0	30	21	0.692	-0.098	3.95	0.016	0.013	0	47.7	44.7	66.7	145	137	0	34	33
2015	7	31	0	40	21	0.676	-0.075	3.953	0.013	0.01	0	47.7	44.7	65.4	145	137	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	31	0	50	21	0.702	-0.082	3.953	0.01	0.007	0	47.7	44.7	66.7	145	137	0	34	33
2015	7	31	1	0	21	0.699	-0.089	3.953	0.01	0.007	0	47.3	43.9	66.2	144	135	0	34	33
2015	7	31	1	10	21	0.679	-0.098	3.953	0.016	0.013	0	46.9	44.3	66.7	143	136	0	34	33
2015	7	31	1	20	21	0.702	-0.082	3.957	0.013	0.01	0	46.9	43.9	67.5	143	135	0	34	33
2015	7	31	1	30	21	0.679	-0.082	3.957	0.01	0.007	0	47.3	44.3	66.7	144	136	0	34	33
2015	7	31	1	40	21	0.689	-0.121	3.957	0.013	0.01	0	47.3	43.9	64.9	144	135	0	34	33
2015	7	31	1	50	21	0.692	-0.108	3.957	0.01	0.007	0	46.9	44.3	67.1	144	137	0	35	34
2015	7	31	2	0	21	0.722	-0.095	3.957	0.013	0.01	0	47.3	44.3	67.1	144	136	0	34	33
2015	7	31	2	10	21	0.709	-0.098	3.957	0.013	0.01	0	46.4	43.9	68.4	143	135	0	35	33
2015	7	31	2	20	21	0.715	-0.056	3.957	0.013	0.01	0	46.9	44.3	67.5	144	136	0	35	33
2015	7	31	2	30	21	0.663	-0.098	3.96	0.013	0.01	0	47.3	43.9	68.8	144	135	0	34	33
2015	7	31	2	40	21	0.686	-0.085	3.96	0.01	0.007	0	46.9	43.4	67.9	144	135	0	35	34
2015	7	31	2	50	21	0.643	-0.052	3.96	0.013	0.01	0	47.7	45.2	67.5	145	137	0	34	32
2015	7	31	3	0	21	0.679	-0.066	3.96	0.013	0.01	0	47.7	44.7	66.2	145	136	0	34	32
2015	7	31	3	10	21	0.656	-0.089	3.96	0.01	0.007	0	47.7	44.7	66.7	145	137	0	34	33
2015	7	31	3	20	21	0.666	-0.062	3.96	0.013	0.01	0	47.7	44.3	61.5	145	136	0	34	33
2015	7	31	3	30	21	0.65	-0.072	3.96	0.01	0.007	0	47.7	44.7	68.4	145	137	0	34	33
2015	7	31	3	40	21	0.679	-0.066	3.96	0.01	0.007	0	47.3	44.3	69.2	144	136	0	34	33
2015	7	31	3	50	21	0.705	-0.056	3.96	0.013	0.01	0	47.3	44.3	67.9	145	136	0	35	33
2015	7	31	4	0	21	0.653	-0.066	3.96	0.013	0.01	0	47.7	44.3	69.2	145	136	0	34	33
2015	7	31	4	10	21	0.659	-0.128	3.96	0.016	0.013	0	46.4	43.4	56.3	142	134	0	34	33
2015	7	31	4	20	21	0.702	-0.082	3.96	0.01	0.007	0	47.3	44.3	67.5	144	136	0	34	33
2015	7	31	4	30	21	0.676	-0.085	3.963	0.01	0.007	0	47.3	44.3	66.7	144	136	0	34	33
2015	7	31	4	40	21	0.696	-0.098	3.963	0.016	0.013	0	46.9	43.9	66.2	143	135	0	34	33
2015	7	31	4	50	21	0.663	-0.075	3.96	0.01	0.007	0	47.7	44.3	55.5	145	136	0	34	33
2015	7	31	5	0	21	0.692	-0.082	3.963	0.01	0.007	0	47.3	44.7	69.2	144	136	0	34	32
2015	7	31	5	10	21	0.676	-0.082	3.963	0.01	0.007	0	47.7	44.7	69.7	145	137	0	34	33
2015	7	31	5	20	21	0.679	-0.092	3.963	0.01	0.007	0	47.7	44.7	70.1	145	137	0	34	33
2015	7	31	5	30	21	0.699	-0.066	3.963	0.01	0.007	0	46.9	44.3	70.1	144	136	0	35	33
2015	7	31	5	40	21	0.696	-0.085	3.963	0.013	0.01	0	46.9	44.3	70.1	144	136	0	35	33
2015	7	31	5	50	21	0.659	-0.092	3.963	0.016	0.013	0	47.3	44.3	70.1	144	136	0	34	33
2015	7	31	6	0	21	0.676	-0.095	3.963	0.013	0.01	0	47.3	43.9	70.5	144	135	0	34	33
2015	7	31	6	10	21	0.686	-0.092	3.963	0.01	0.007	0	47.3	43.9	71	144	135	0	34	33
2015	7	31	6	20	21	0.702	-0.102	3.963	0.016	0.013	0	46.9	43.4	70.1	143	134	0	34	33
2015	7	31	6	30	21	0.673	-0.095	3.967	0.016	0.013	0	46.9	43.9	70.1	143	135	0	34	33
2015	7	31	6	40	21	0.682	-0.066	3.967	0.013	0.01	0	46.4	43.4	70.5	142	134	0	34	33
2015	7	31	6	50	21	0.689	-0.079	3.967	0.01	0.007	0	46.9	43.4	70.1	142	134	0	33	33
2015	7	31	7	0	21	0.673	-0.085	3.967	0.013	0.01	0	46.9	43.4	71.4	143	134	0	34	33
2015	7	31	7	10	21	0.705	-0.105	3.967	0.01	0.007	0	46.4	43.4	70.1	142	133	0	34	32
2015	7	31	7	20	21	0.692	-0.082	3.967	0.01	0.007	0	46.4	43.4	71	142	134	0	34	33
2015	7	31	7	30	21	0.689	-0.089	3.967	0.013	0.01	0	46.4	43.4	64.5	142	134	0	34	33
2015	7	31	7	40	21	0.679	-0.092	3.967	0.013	0.01	0	46.9	43.4	62.4	143	134	0	34	33
2015	7	31	7	50	21	0.686	-0.085	3.967	0.01	0.007	0	46.4	43.4	70.5	142	134	0	34	33
2015	7	31	8	0	21	0.676	-0.102	3.967	0.01	0.007	0	46.4	43	65.8	142	133	0	34	33
2015	7	31	8	10	21	0.676	-0.082	3.967	0.01	0.007	0	46	43.4	68.8	142	134	0	35	33
2015	7	31	8	20	21	0.686	-0.075	3.967	0.013	0.01	0	46	43.4	69.7	142	134	0	35	33
2015	7	31	8	30	21	0.692	-0.056	3.967	0.01	0.007	0	46	43	67.9	141	133	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	31	8	40	21	0.682	-0.102	3.967	0.013	0.01	0	45.6	43	71	140	133	0	34	33
2015	7	31	8	50	21	0.715	-0.066	3.967	0.01	0.007	0	46	42.6	70.5	141	133	0	34	34
2015	7	31	9	0	21	0.692	-0.089	3.967	0.01	0.007	0	46	43	70.1	141	133	0	34	33
2015	7	31	9	10	21	0.722	-0.095	3.967	0.013	0.01	0	46	42.6	70.5	141	132	0	34	33
2015	7	31	9	20	21	0.692	-0.062	3.967	0.013	0.01	0	46	42.6	71	141	132	0	34	33
2015	7	31	9	30	21	0.712	-0.085	3.967	0.01	0.007	0	46	42.6	71	141	132	0	34	33
2015	7	31	9	40	21	0.682	-0.082	3.967	0.01	0.007	0	46.4	43	69.2	142	133	0	34	33
2015	7	31	9	50	21	0.732	-0.115	3.967	0.016	0.013	0	46.4	43	70.1	142	133	0	34	33
2015	7	31	10	0	21	0.682	-0.062	3.967	0.016	0.013	0	46	43	70.5	141	133	0	34	33
2015	7	31	10	10	21	0.692	-0.135	3.967	0.01	0.007	0	46	42.6	70.1	142	133	0	35	34
2015	7	31	10	20	21	0.699	-0.079	3.967	0.01	0.007	0	46.4	43	70.1	142	133	0	34	33
2015	7	31	10	30	21	0.699	-0.118	3.967	0.016	0.013	0	46.4	43.4	71	142	134	0	34	33
2015	7	31	10	40	21	0.709	-0.082	3.967	0.01	0.007	0	46.4	43	62.8	141	133	0	33	33
2015	7	31	10	50	21	0.682	-0.112	3.967	0.01	0.007	0	45.6	43	71	141	133	0	35	33
2015	7	31	11	0	21	0.709	-0.092	3.967	0.01	0.007	0	46	43	68.8	141	133	0	34	33
2015	7	31	11	10	21	0.702	-0.059	3.967	0.01	0.007	0	46.4	43	70.5	142	133	0	34	33
2015	7	31	11	20	21	0.669	-0.075	3.967	0.013	0.01	0	46	43	71	141	133	0	34	33
2015	7	31	11	30	21	0.686	-0.066	3.967	0.01	0.007	0	46	43	71	141	133	0	34	33
2015	7	31	11	40	21	0.705	-0.102	3.967	0.013	0.01	0	46	43	71	141	133	0	34	33
2015	7	31	11	50	21	0.679	-0.085	3.967	0.013	0.01	0	46	43.4	69.7	141	134	0	34	33
2015	7	31	12	0	21	0.673	-0.062	3.967	0.013	0.01	0	46	43	70.5	141	133	0	34	33
2015	7	31	12	10	21	0.679	-0.092	3.967	0.013	0.01	0	46.4	43.4	71	142	134	0	34	33
2015	7	31	12	20	21	0.705	-0.072	3.967	0.01	0.007	0	46.4	43	71	142	133	0	34	33
2015	7	31	12	30	21	0.669	-0.085	3.967	0.01	0.007	0	46	43	70.5	141	133	0	34	33
2015	7	31	12	40	21	0.705	-0.102	3.967	0.01	0.007	0	46	43	71.4	141	133	0	34	33
2015	7	31	12	50	21	0.699	-0.095	3.967	0.013	0.01	0	46.4	43.4	67.9	142	134	0	34	33
2015	7	31	13	0	21	0.696	-0.098	3.967	0.013	0.01	0	46	43.4	70.5	141	133	0	34	32
2015	7	31	13	10	21	0.663	-0.102	3.967	0.016	0.013	0	46	43	70.1	141	133	0	34	33
2015	7	31	13	20	21	0.696	-0.128	3.967	0.01	0.007	0	45.6	42.1	71.4	140	132	0	34	34
2015	7	31	13	30	21	0.689	-0.102	3.967	0.013	0.01	0	46	43	70.1	141	133	0	34	33
2015	7	31	13	40	21	0.702	-0.125	3.967	0.01	0.007	0	45.2	43	71.8	139	132	0	34	32
2015	7	31	13	50	21	0.712	-0.128	3.967	0.01	0.007	0	45.6	42.6	71	140	132	0	34	33
2015	7	31	14	0	21	0.699	-0.092	3.967	0.013	0.01	0	46.4	43.4	69.7	142	134	0	34	33
2015	7	31	14	10	21	0.686	-0.102	3.967	0.01	0.007	0	45.6	43	69.2	140	133	0	34	33
2015	7	31	14	20	21	0.682	-0.095	3.967	0.01	0.007	0	45.6	42.6	69.2	141	133	0	35	34
2015	7	31	14	30	21	0.719	-0.115	3.967	0.01	0.007	0	46	43	69.2	141	133	0	34	33
2015	7	31	14	40	21	0.673	-0.089	3.967	0.013	0.01	0	45.6	43	65.8	141	133	0	35	33
2015	7	31	14	50	21	0.669	-0.082	3.967	0.01	0.007	0	46.4	43	69.7	141	133	0	33	33
2015	7	31	15	0	21	0.689	-0.079	3.967	0.01	0.007	0	46	43	69.2	141	133	0	34	33
2015	7	31	15	10	21	0.673	-0.079	3.963	0.01	0.007	0	46.4	42.6	64.5	141	133	0	33	34
2015	7	31	15	20	21	0.663	-0.089	3.963	0.013	0.01	0	46	43	65.8	141	133	0	34	33
2015	7	31	15	30	21	0.673	-0.112	3.963	0.01	0.007	0	44.7	42.1	67.9	138	131	0	34	33
2015	7	31	15	40	21	0.679	-0.098	3.963	0.016	0.016	0	45.2	42.6	67.9	139	132	0	34	33
2015	7	31	15	50	21	0.696	-0.069	3.963	0.013	0.01	0	45.2	42.1	65.8	139	131	0	34	33
2015	7	31	16	0	21	0.686	-0.125	3.96	0.013	0.01	0	45.2	42.1	55.9	139	131	0	34	33
2015	7	31	16	10	21	0.696	-0.102	3.963	0.013	0.01	0	45.2	42.6	64.9	139	132	0	34	33
2015	7	31	16	20	21	0.679	-0.151	3.96	0.01	0.007	0	44.3	41.7	54.6	137	130	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	31	16	30	21	0.679	-0.108	3.96	0.01	0.007	0	44.3	41.3	65.8	137	129	0	34	33
2015	7	31	16	40	21	0.702	-0.131	3.96	0.01	0.007	0	45.2	42.1	64.5	139	131	0	34	33
2015	7	31	16	50	21	0.653	-0.098	3.96	0.013	0.01	0	45.6	43	61.5	140	133	0	34	33
2015	7	31	17	0	21	0.696	-0.079	3.96	0.016	0.013	0	45.2	42.6	68.4	139	132	0	34	33
2015	7	31	17	10	21	0.699	-0.059	3.96	0.01	0.007	0	46	43.9	67.1	141	134	0	34	32
2015	7	31	17	20	21	0.699	-0.098	3.96	0.013	0.01	0	45.2	43	67.5	140	133	0	35	33
2015	7	31	17	30	21	0.689	-0.082	3.96	0.01	0.007	0	45.6	43	64.9	140	133	0	34	33
2015	7	31	17	40	21	0.689	-0.052	3.96	0.01	0.007	0	45.6	43	64.5	140	133	0	34	33
2015	7	31	17	50	21	0.689	-0.089	3.96	0.01	0.007	0	45.6	43	67.5	141	133	0	35	33
2015	7	31	18	0	21	0.686	-0.098	3.96	0.01	0.007	0	46	42.6	68.4	141	132	0	34	33
2015	7	31	18	10	21	0.686	-0.082	3.96	0.016	0.013	0	46	42.6	66.7	141	132	0	34	33
2015	7	31	18	20	21	0.666	-0.079	3.96	0.01	0.007	0	46.4	43	65.4	142	133	0	34	33
2015	7	31	18	30	21	0.682	-0.102	3.96	0.013	0.01	0	46	43	67.5	141	133	0	34	33
2015	7	31	18	40	21	0.679	-0.102	3.96	0.01	0.007	0	45.6	42.6	66.2	140	132	0	34	33
2015	7	31	18	50	21	0.699	-0.066	3.96	0.013	0.01	0	45.2	43	65.8	140	132	0	35	32
2015	7	31	19	0	21	0.702	-0.085	3.96	0.01	0.007	0	46	42.6	67.1	141	132	0	34	33
2015	7	31	19	10	21	0.686	-0.069	3.96	0.013	0.01	0	46	42.6	67.5	141	132	0	34	33
2015	7	31	19	20	21	0.676	-0.085	3.96	0.013	0.01	0	46	43	67.1	141	133	0	34	33
2015	7	31	19	30	21	0.676	-0.092	3.96	0.013	0.01	0	46	43	68.4	141	133	0	34	33
2015	7	31	19	40	21	0.712	-0.082	3.96	0.01	0.007	0	46.9	43.4	67.9	143	135	0	34	34
2015	7	31	19	50	21	0.65	-0.072	3.96	0.01	0.007	0	46.9	43.9	67.9	143	135	0	34	33
2015	7	31	20	0	21	0.692	-0.085	3.96	0.013	0.01	0	46.9	43.9	68.4	143	134	0	34	32
2015	7	31	20	10	21	0.669	-0.092	3.96	0.01	0.007	0	47.7	44.3	68.4	145	136	0	34	33
2015	7	31	20	20	21	0.679	-0.066	3.96	0.013	0.01	0	47.3	44.3	67.5	144	136	0	34	33
2015	7	31	20	30	21	0.656	-0.105	3.963	0.013	0.01	0	47.7	44.7	67.5	145	137	0	34	33
2015	7	31	20	40	21	0.679	-0.085	3.963	0.01	0.007	0	47.7	45.2	66.2	145	137	0	34	32
2015	7	31	20	50	21	0.686	-0.075	3.963	0.01	0.007	0	47.3	45.2	64.9	145	137	0	35	32
2015	7	31	21	0	21	0.666	-0.079	3.963	0.01	0.007	0	48.2	44.7	59.3	145	137	0	33	33
2015	7	31	21	10	21	0.673	-0.095	3.963	0.01	0.007	0	47.3	43.9	65.4	144	135	0	34	33
2015	7	31	21	20	21	0.702	-0.082	3.963	0.01	0.007	0	47.7	44.7	68.4	145	137	0	34	33
2015	7	31	21	30	21	0.673	-0.089	3.963	0.016	0.013	0	46.9	43.4	68.8	143	134	0	34	33
2015	7	31	21	40	21	0.679	-0.102	3.963	0.016	0.013	0	46.9	44.3	68.4	144	136	0	35	33
2015	7	31	21	50	21	0.692	-0.069	3.963	0.01	0.007	0	48.2	44.7	67.9	146	137	0	34	33
2015	7	31	22	0	21	0.659	-0.092	3.963	0.01	0.007	0	46.9	44.3	68.4	144	136	0	35	33
2015	7	31	22	10	21	0.699	-0.098	3.967	0.013	0.01	0	47.3	44.7	69.2	144	136	0	34	32
2015	7	31	22	20	21	0.673	-0.105	3.967	0.01	0.007	0	47.3	44.3	69.2	144	136	0	34	33
2015	7	31	22	30	21	0.696	-0.069	3.967	0.01	0.007	0	48.2	44.3	69.2	145	136	0	33	33
2015	7	31	22	40	21	0.653	-0.085	3.967	0.013	0.01	0	47.7	43.9	69.2	144	135	0	33	33
2015	7	31	22	50	21	0.65	-0.066	3.967	0.01	0.007	0	47.3	44.3	69.2	144	136	0	34	33
2015	7	31	23	0	21	0.663	-0.069	3.967	0.01	0.007	0	47.3	44.3	66.7	145	136	0	35	33
2015	7	31	23	10	21	0.699	-0.105	3.967	0.01	0.007	0	47.3	44.3	70.1	144	136	0	34	33
2015	7	31	23	20	21	0.696	-0.089	3.967	0.01	0.007	0	47.3	44.3	70.5	144	135	0	34	32
2015	7	31	23	30	21	0.669	-0.052	3.97	0.013	0.01	0	47.3	44.3	69.7	144	136	0	34	33
2015	7	31	23	40	21	0.696	-0.046	3.97	0.02	0.016	0	46.4	43.9	69.2	142	135	0	34	33
2015	7	31	23	50	21	0.686	-0.059	3.97	0.01	0.007	0	46.9	43.9	70.5	143	135	0	34	33

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	1	0	4	8	34		0	0	0	0	0	0	73.44	0	0	12.2
2015	7	1	0	14	8	34		0	0	0	0	0	0	73.45	0	0	12.2
2015	7	1	0	24	8	34		0	0	0	0	0	0	73.47	0	0	12.2
2015	7	1	0	34	8	34		0	0	0	0	0	0	73.47	0	0	12
2015	7	1	0	44	8	34		0	0	0	0	0	0	73.45	0	0	12
2015	7	1	0	54	8	35		0	0	0	0	0	0	73.45	0	0	12
2015	7	1	1	4	8	33		0	0	0	0	0	0	73.45	0	0	12
2015	7	1	1	14	8	34		0	0	0	0	0	0	73.45	0	0	12
2015	7	1	1	24	8	34		0	0	0	0	0	0	73.45	0	0	12
2015	7	1	1	34	8	34		0	0	0	0	0	0	73.44	0	0	12
2015	7	1	1	44	8	34		0	0	0	0	0	0	73.44	0	0	12
2015	7	1	1	54	8	34		0	0	0	0	0	0	73.42	0	0	12
2015	7	1	2	4	8	34		0	0	0	0	0	0	73.4	0	0	12
2015	7	1	2	14	8	34		0	0	0	0	0	0	73.38	0	0	12
2015	7	1	2	24	8	33		0	0	0	0	0	0	73.38	0	0	12
2015	7	1	2	34	8	33		0	0	0	0	0	0	73.35	0	0	12
2015	7	1	2	44	8	34		0	0	0	0	0	0	73.33	0	0	12
2015	7	1	2	54	8	34		0	0	0	0	0	0	73.31	0	0	12
2015	7	1	3	4	8	34		0	0	0	0	0	0	73.27	0	0	12
2015	7	1	3	14	8	34		0	0	0	0	0	0	73.24	0	0	12
2015	7	1	3	24	8	34		0	0	0	0	0	0	73.22	0	0	12
2015	7	1	3	34	8	34		0	0	0	0	0	0	73.18	0	0	12
2015	7	1	3	44	8	34		0	0	0	0	0	0	73.15	0	0	12
2015	7	1	3	54	8	34		0	0	0	0	0	0	73.11	0	0	12
2015	7	1	4	4	8	34		0	0	0	0	0	0	73.09	0	0	12
2015	7	1	4	14	8	34		0	0	0	0	0	0	73.06	0	0	12
2015	7	1	4	24	8	34		0	0	0	0	0	0	73.04	0	0	12
2015	7	1	4	34	8	34		0	0	0	0	0	0	73	0	0	12
2015	7	1	4	44	8	34		0	0	0	0	0	0	72.99	0	0	12
2015	7	1	4	54	8	34		0	0	0	0	0	0	72.95	0	0	12
2015	7	1	5	4	8	34		0	0	0	0	0	0	72.91	0	0	12
2015	7	1	5	14	8	34		0	0	0	0	0	0	72.9	0	0	12
2015	7	1	5	24	8	34		0	0	0	0	0	0	72.86	0	0	12
2015	7	1	5	34	8	34		0	0	0	0	0	0	72.84	0	0	12
2015	7	1	5	44	8	34		0	0	0	0	0	0	72.82	0	0	12
2015	7	1	5	54	8	33		0	0	0	0	0	0	72.79	0	0	12
2015	7	1	6	4	8	34		0	0	0	0	0	0	72.73	0	0	12
2015	7	1	6	14	8	33		0	0	0	0	0	0	72.7	0	0	12
2015	7	1	6	24	8	35		0	0	0	0	0	0	72.66	0	0	12
2015	7	1	6	34	8	34		0	0	0	0	0	0	72.63	0	0	12
2015	7	1	6	44	8	34		0	0	0	0	0	0	72.59	0	0	12
2015	7	1	6	54	8	35		0	0	0	0	0	0	72.55	0	0	12
2015	7	1	7	4	8	35		0	0	0	0	0	0	72.55	0	0	12
2015	7	1	7	14	8	34		0	0	0	0	0	0	72.54	0	0	12
2015	7	1	7	24	8	34		0	0	0	0	0	0	72.52	0	0	12
2015	7	1	7	34	8	34		0	0	0	0	0	0	72.5	0	0	12
2015	7	1	7	44	8	34		0	0	0	0	0	0	72.48	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	1	7	54	8	34		0	0	0	0	0	0	72.46	0	0	12
2015	7	1	8	4	8	34		0	0	0	0	0	0	72.45	0	0	12
2015	7	1	8	14	8	34		0	0	0	0	0	0	72.43	0	0	12
2015	7	1	8	24	8	34		0	0	0	0	0	0	72.41	0	0	12
2015	7	1	8	34	8	33		0	0	0	0	0	0	72.39	0	0	12
2015	7	1	8	44	8	34		0	0	0	0	0	0	72.39	0	0	12
2015	7	1	8	54	8	35		0	0	0	0	0	0	72.39	0	0	12
2015	7	1	9	4	8	35		0	0	0	0	0	0	72.37	0	0	12
2015	7	1	9	14	8	34		0	0	0	0	0	0	72.37	0	0	12
2015	7	1	9	24	8	34		0	0	0	0	0	0	72.36	0	0	12
2015	7	1	9	34	8	34		0	0	0	0	0	0	72.34	0	0	12
2015	7	1	9	44	8	34		0	0	0	0	0	0	72.32	0	0	12
2015	7	1	9	54	8	34		0	0	0	0	0	0	72.32	0	0	12
2015	7	1	10	4	8	34		0	0	0	0	0	0	72.32	0	0	12.2
2015	7	1	10	14	8	34		0	0	0	0	0	0	72.34	0	0	12.2
2015	7	1	10	24	8	34		0	0	0	0	0	0	72.34	0	0	12.2
2015	7	1	10	34	8	34		0	0	0	0	0	0	72.28	0	0	12.2
2015	7	1	10	44	8	34		0	0	0	0	0	0	72.27	0	0	12
2015	7	1	10	54	8	34		0	0	0	0	0	0	72.25	0	0	12
2015	7	1	11	4	8	35		0	0	0	0	0	0	72.27	0	0	12.2
2015	7	1	11	14	8	34		0	0	0	0	0	0	72.32	0	0	12.4
2015	7	1	11	24	8	34		0	0	0	0	0	0	72.34	0	0	12.6
2015	7	1	11	34	8	34		0	0	0	0	0	0	72.37	0	0	12.8
2015	7	1	11	44	8	35		0	0	0	0	0	0	72.37	0	0	12.8
2015	7	1	11	54	8	34		0	0	0	0	0	0	72.37	0	0	12.8
2015	7	1	12	4	8	35		0	0	0	0	0	0	72.41	0	0	12.8
2015	7	1	12	14	8	34		0	0	0	0	0	0	72.37	0	0	12.6
2015	7	1	12	24	8	33		0	0	0	0	0	0	72.39	0	0	12.8
2015	7	1	12	34	8	34		0	0	0	0	0	0	72.39	0	0	12.8
2015	7	1	12	44	8	34		0	0	0	0	0	0	72.57	0	0	13.4
2015	7	1	12	54	8	34		0	0	0	0	0	0	72.46	0	0	12.8
2015	7	1	13	4	8	34		0	0	0	0	0	0	72.41	0	0	12.8
2015	7	1	13	14	8	34		0	0	0	0	0	0	72.41	0	0	12.6
2015	7	1	13	24	8	34		0	0	0	0	0	0	72.41	0	0	12.8
2015	7	1	13	34	8	34		0	0	0	0	0	0	72.5	0	0	13.2
2015	7	1	13	44	8	34		0	0	0	0	0	0	72.45	0	0	12.6
2015	7	1	13	54	8	34		0	0	0	0	0	0	72.52	0	0	13.2
2015	7	1	14	4	8	34		0	0	0	0	0	0	72.68	0	0	13.4
2015	7	1	14	14	8	34		0	0	0	0	0	0	72.73	0	0	13.4
2015	7	1	14	24	8	35		0	0	0	0	0	0	72.73	0	0	13.2
2015	7	1	14	34	8	34		0	0	0	0	0	0	72.77	0	0	13.2
2015	7	1	14	44	8	34		0	0	0	0	0	0	72.75	0	0	13.2
2015	7	1	14	54	8	34		0	0	0	0	0	0	72.73	0	0	13.2
2015	7	1	15	4	8	34		0	0	0	0	0	0	72.79	0	0	13.2
2015	7	1	15	14	8	34		0	0	0	0	0	0	72.72	0	0	13.2
2015	7	1	15	24	8	34		0	0	0	0	0	0	72.66	0	0	13.2
2015	7	1	15	34	8	35		0	0	0	0	0	0	72.59	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	1	15	44	8	34		0	0	0	0	0	0	72.57	0	0	13.2
2015	7	1	15	54	8	34		0	0	0	0	0	0	72.54	0	0	13.2
2015	7	1	16	4	8	34		0	0	0	0	0	0	72.61	0	0	13.2
2015	7	1	16	14	8	34		0	0	0	0	0	0	72.68	0	0	13.2
2015	7	1	16	24	8	34		0	0	0	0	0	0	72.59	0	0	13.2
2015	7	1	16	34	8	34		0	0	0	0	0	0	72.61	0	0	13.2
2015	7	1	16	44	8	34		0	0	0	0	0	0	72.61	0	0	13.2
2015	7	1	16	54	8	34		0	0	0	0	0	0	72.61	0	0	13.2
2015	7	1	17	4	8	34		0	0	0	0	0	0	72.57	0	0	13.2
2015	7	1	17	14	8	34		0	0	0	0	0	0	72.55	0	0	13.2
2015	7	1	17	24	8	34		0	0	0	0	0	0	72.55	0	0	13.2
2015	7	1	17	34	8	34		0	0	0	0	0	0	72.52	0	0	13.2
2015	7	1	17	44	8	35		0	0	0	0	0	0	72.5	0	0	13.2
2015	7	1	17	54	8	35		0	0	0	0	0	0	72.48	0	0	13.2
2015	7	1	18	4	8	34		0	0	0	0	0	0	72.5	0	0	13.2
2015	7	1	18	14	8	34		0	0	0	0	0	0	72.48	0	0	13.2
2015	7	1	18	24	8	34		0	0	0	0	0	0	72.48	0	0	12.6
2015	7	1	18	34	8	34		0	0	0	0	0	0	72.5	0	0	12.4
2015	7	1	18	44	8	34		0	0	0	0	0	0	72.5	0	0	12.2
2015	7	1	18	54	8	35		0	0	0	0	0	0	72.5	0	0	12.2
2015	7	1	19	4	8	35		0	0	0	0	0	0	72.5	0	0	12.2
2015	7	1	19	14	8	34		0	0	0	0	0	0	72.5	0	0	12.2
2015	7	1	19	24	8	34		0	0	0	0	0	0	72.52	0	0	12.2
2015	7	1	19	34	8	34		0	0	0	0	0	0	72.52	0	0	12.2
2015	7	1	19	44	8	34		0	0	0	0	0	0	72.54	0	0	12.2
2015	7	1	19	54	8	34		0	0	0	0	0	0	72.54	0	0	12.2
2015	7	1	20	4	8	35		0	0	0	0	0	0	72.55	0	0	12.2
2015	7	1	20	14	8	35		0	0	0	0	0	0	72.57	0	0	12.2
2015	7	1	20	24	8	34		0	0	0	0	0	0	72.57	0	0	12.2
2015	7	1	20	34	8	35		0	0	0	0	0	0	72.59	0	0	12.2
2015	7	1	20	44	8	35		0	0	0	0	0	0	72.61	0	0	12.2
2015	7	1	20	54	8	34		0	0	0	0	0	0	72.63	0	0	12.2
2015	7	1	21	4	8	35		0	0	0	0	0	0	72.63	0	0	12.2
2015	7	1	21	14	8	33		0	0	0	0	0	0	72.64	0	0	12.2
2015	7	1	21	24	8	33		0	0	0	0	0	0	72.66	0	0	12.2
2015	7	1	21	34	8	34		0	0	0	0	0	0	72.68	0	0	12.2
2015	7	1	21	44	8	34		0	0	0	0	0	0	72.7	0	0	12.2
2015	7	1	21	54	8	35		0	0	0	0	0	0	72.73	0	0	12.2
2015	7	1	22	4	8	34		0	0	0	0	0	0	72.75	0	0	12.2
2015	7	1	22	14	8	34		0	0	0	0	0	0	72.75	0	0	12.2
2015	7	1	22	24	8	34		0	0	0	0	0	0	72.77	0	0	12.2
2015	7	1	22	34	8	34		0	0	0	0	0	0	72.79	0	0	12.2
2015	7	1	22	44	8	34		0	0	0	0	0	0	72.82	0	0	12.2
2015	7	1	22	54	8	34		0	0	0	0	0	0	72.82	0	0	12.2
2015	7	1	23	4	8	34		0	0	0	0	0	0	72.84	0	0	12.2
2015	7	1	23	14	8	34		0	0	0	0	0	0	72.86	0	0	12.2
2015	7	1	23	24	8	34		0	0	0	0	0	0	72.86	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	1	23	34	8	34	0	0	0	0	0	0	0	72.88	0	0	12
2015	7	1	23	44	8	34	0	0	0	0	0	0	0	72.9	0	0	12.2
2015	7	1	23	54	8	35	0	0	0	0	0	0	0	72.9	0	0	12.2
2015	7	2	0	4	8	34	0	0	0	0	0	0	0	72.91	0	0	12.2
2015	7	2	0	14	8	34	0	0	0	0	0	0	0	72.91	0	0	12.2
2015	7	2	0	24	8	35	0	0	0	0	0	0	0	72.93	0	0	12.2
2015	7	2	0	34	8	34	0	0	0	0	0	0	0	72.95	0	0	12
2015	7	2	0	44	8	34	0	0	0	0	0	0	0	72.95	0	0	12.2
2015	7	2	0	54	8	34	0	0	0	0	0	0	0	72.95	0	0	12.2
2015	7	2	1	4	8	34	0	0	0	0	0	0	0	72.95	0	0	12
2015	7	2	1	14	8	34	0	0	0	0	0	0	0	72.97	0	0	12
2015	7	2	1	24	8	34	0	0	0	0	0	0	0	72.97	0	0	12
2015	7	2	1	34	8	33	0	0	0	0	0	0	0	72.97	0	0	12
2015	7	2	1	44	8	35	0	0	0	0	0	0	0	72.95	0	0	12
2015	7	2	1	54	8	34	0	0	0	0	0	0	0	72.97	0	0	12
2015	7	2	2	4	8	34	0	0	0	0	0	0	0	72.95	0	0	12
2015	7	2	2	14	8	35	0	0	0	0	0	0	0	72.97	0	0	12
2015	7	2	2	24	8	33	0	0	0	0	0	0	0	72.95	0	0	12
2015	7	2	2	34	8	34	0	0	0	0	0	0	0	72.97	0	0	12
2015	7	2	2	44	8	35	0	0	0	0	0	0	0	72.95	0	0	12
2015	7	2	2	54	8	34	0	0	0	0	0	0	0	72.95	0	0	12
2015	7	2	3	4	8	34	0	0	0	0	0	0	0	72.93	0	0	12
2015	7	2	3	14	8	34	0	0	0	0	0	0	0	72.93	0	0	12
2015	7	2	3	24	8	34	0	0	0	0	0	0	0	72.91	0	0	12
2015	7	2	3	34	8	34	0	0	0	0	0	0	0	72.91	0	0	12
2015	7	2	3	44	8	34	0	0	0	0	0	0	0	72.9	0	0	12
2015	7	2	3	54	8	34	0	0	0	0	0	0	0	72.9	0	0	12
2015	7	2	4	4	8	35	0	0	0	0	0	0	0	72.9	0	0	12
2015	7	2	4	14	8	35	0	0	0	0	0	0	0	72.88	0	0	12
2015	7	2	4	24	8	34	0	0	0	0	0	0	0	72.88	0	0	12
2015	7	2	4	34	8	34	0	0	0	0	0	0	0	72.84	0	0	12
2015	7	2	4	44	8	34	0	0	0	0	0	0	0	72.84	0	0	12
2015	7	2	4	54	8	34	0	0	0	0	0	0	0	72.84	0	0	12
2015	7	2	5	4	8	35	0	0	0	0	0	0	0	72.82	0	0	12
2015	7	2	5	14	8	34	0	0	0	0	0	0	0	72.81	0	0	12
2015	7	2	5	24	8	34	0	0	0	0	0	0	0	72.79	0	0	12
2015	7	2	5	34	8	34	0	0	0	0	0	0	0	72.79	0	0	12
2015	7	2	5	44	8	34	0	0	0	0	0	0	0	72.77	0	0	12
2015	7	2	5	54	8	34	0	0	0	0	0	0	0	72.75	0	0	12
2015	7	2	6	4	8	34	0	0	0	0	0	0	0	72.73	0	0	12
2015	7	2	6	14	8	33	0	0	0	0	0	0	0	72.73	0	0	12
2015	7	2	6	24	8	34	0	0	0	0	0	0	0	72.72	0	0	12
2015	7	2	6	34	8	35	0	0	0	0	0	0	0	72.72	0	0	12
2015	7	2	6	44	8	35	0	0	0	0	0	0	0	72.72	0	0	12
2015	7	2	6	54	8	34	0	0	0	0	0	0	0	72.72	0	0	12
2015	7	2	7	4	8	34	0	0	0	0	0	0	0	72.7	0	0	12
2015	7	2	7	14	8	34	0	0	0	0	0	0	0	72.7	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	2	7	24	8	34		0	0	0	0	0	0	72.72	0	0	12.2
2015	7	2	7	34	8	34		0	0	0	0	0	0	72.73	0	0	12.4
2015	7	2	7	44	8	34		0	0	0	0	0	0	72.75	0	0	12.6
2015	7	2	7	54	8	34		0	0	0	0	0	0	72.77	0	0	12.6
2015	7	2	8	4	8	34		0	0	0	0	0	0	72.79	0	0	12.6
2015	7	2	8	14	8	34		0	0	0	0	0	0	72.77	0	0	12.6
2015	7	2	8	24	8	34		0	0	0	0	0	0	72.75	0	0	12.6
2015	7	2	8	34	8	34		0	0	0	0	0	0	72.75	0	0	12.4
2015	7	2	8	44	8	34		0	0	0	0	0	0	72.75	0	0	12.6
2015	7	2	8	54	8	34		0	0	0	0	0	0	72.75	0	0	12.6
2015	7	2	9	4	8	34		0	0	0	0	0	0	72.75	0	0	12.6
2015	7	2	9	14	8	34		0	0	0	0	0	0	72.75	0	0	12.6
2015	7	2	9	24	8	33		0	0	0	0	0	0	72.75	0	0	12.6
2015	7	2	9	34	8	35		0	0	0	0	0	0	72.79	0	0	12.6
2015	7	2	9	44	8	34		0	0	0	0	0	0	72.81	0	0	12.6
2015	7	2	9	54	8	34		0	0	0	0	0	0	72.88	0	0	12.8
2015	7	2	10	4	8	34		0	0	0	0	0	0	72.88	0	0	12.8
2015	7	2	10	14	8	34		0	0	0	0	0	0	72.9	0	0	12.8
2015	7	2	10	24	8	34		0	0	0	0	0	0	72.91	0	0	12.8
2015	7	2	10	34	8	34		0	0	0	0	0	0	72.97	0	0	12.8
2015	7	2	10	44	8	34		0	0	0	0	0	0	72.93	0	0	12.8
2015	7	2	10	54	8	34		0	0	0	0	0	0	72.91	0	0	12.6
2015	7	2	11	4	8	34		0	0	0	0	0	0	72.93	0	0	12.8
2015	7	2	11	14	8	34		0	0	0	0	0	0	72.97	0	0	13
2015	7	2	11	24	8	33		0	0	0	0	0	0	72.95	0	0	12.8
2015	7	2	11	34	8	35		0	0	0	0	0	0	72.95	0	0	12.6
2015	7	2	11	44	8	34		0	0	0	0	0	0	72.95	0	0	12.8
2015	7	2	11	54	8	34		0	0	0	0	0	0	73.11	0	0	13.2
2015	7	2	12	4	8	34		0	0	0	0	0	0	73.15	0	0	13.2
2015	7	2	12	14	8	33		0	0	0	0	0	0	73.13	0	0	13.2
2015	7	2	12	24	8	33		0	0	0	0	0	0	73.13	0	0	13.2
2015	7	2	12	34	8	34		0	0	0	0	0	0	73.18	0	0	13.2
2015	7	2	12	44	8	34		0	0	0	0	0	0	73.33	0	0	13.2
2015	7	2	12	54	8	34		0	0	0	0	0	0	73.35	0	0	13.2
2015	7	2	13	4	8	33		0	0	0	0	0	0	73.44	0	0	13.2
2015	7	2	13	14	8	34		0	0	0	0	0	0	73.44	0	0	13.2
2015	7	2	13	24	8	34		0	0	0	0	0	0	73.42	0	0	13.2
2015	7	2	13	34	8	34		0	0	0	0	0	0	73.29	0	0	13
2015	7	2	13	44	8	34		0	0	0	0	0	0	73.36	0	0	13.2
2015	7	2	13	54	8	34		0	0	0	0	0	0	73.33	0	0	13.2
2015	7	2	14	4	8	34		0	0	0	0	0	0	73.44	0	0	13.2
2015	7	2	14	14	8	34		0	0	0	0	0	0	73.63	0	0	13.2
2015	7	2	14	24	8	34		0	0	0	0	0	0	73.6	0	0	13.2
2015	7	2	14	34	8	34		0	0	0	0	0	0	73.4	0	0	13
2015	7	2	14	44	8	33		0	0	0	0	0	0	73.35	0	0	13.2
2015	7	2	14	54	8	34		0	0	0	0	0	0	73.58	0	0	13.2
2015	7	2	15	4	8	34		0	0	0	0	0	0	73.62	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	2	15	14	8	34	0	0	0	0	0	0	0	73.49	0	0	13
2015	7	2	15	24	8	34	0	0	0	0	0	0	0	73.42	0	0	13
2015	7	2	15	34	8	34	0	0	0	0	0	0	0	73.6	0	0	13.2
2015	7	2	15	44	8	35	0	0	0	0	0	0	0	73.6	0	0	13.2
2015	7	2	15	54	8	34	0	0	0	0	0	0	0	73.62	0	0	13.2
2015	7	2	16	4	8	34	0	0	0	0	0	0	0	73.65	0	0	13
2015	7	2	16	14	8	34	0	0	0	0	0	0	0	73.65	0	0	13
2015	7	2	16	24	8	34	0	0	0	0	0	0	0	73.65	0	0	13
2015	7	2	16	34	8	34	0	0	0	0	0	0	0	73.67	0	0	13
2015	7	2	16	44	8	34	0	0	0	0	0	0	0	73.67	0	0	13
2015	7	2	16	54	8	34	0	0	0	0	0	0	0	73.67	0	0	13
2015	7	2	17	4	8	34	0	0	0	0	0	0	0	73.65	0	0	13
2015	7	2	17	14	8	34	0	0	0	0	0	0	0	73.62	0	0	13
2015	7	2	17	24	8	34	0	0	0	0	0	0	0	73.63	0	0	13
2015	7	2	17	34	8	34	0	0	0	0	0	0	0	73.62	0	0	12.8
2015	7	2	17	44	8	34	0	0	0	0	0	0	0	73.62	0	0	13
2015	7	2	17	54	8	34	0	0	0	0	0	0	0	73.63	0	0	13
2015	7	2	18	4	8	34	0	0	0	0	0	0	0	73.62	0	0	13
2015	7	2	18	14	8	34	0	0	0	0	0	0	0	73.62	0	0	13
2015	7	2	18	24	8	34	0	0	0	0	0	0	0	73.62	0	0	12.8
2015	7	2	18	34	8	34	0	0	0	0	0	0	0	73.63	0	0	12.4
2015	7	2	18	44	8	35	0	0	0	0	0	0	0	73.63	0	0	12.2
2015	7	2	18	54	8	34	0	0	0	0	0	0	0	73.62	0	0	12.2
2015	7	2	19	4	8	34	0	0	0	0	0	0	0	73.62	0	0	12.2
2015	7	2	19	14	8	33	0	0	0	0	0	0	0	73.63	0	0	12.2
2015	7	2	19	24	8	34	0	0	0	0	0	0	0	73.63	0	0	12.2
2015	7	2	19	34	8	34	0	0	0	0	0	0	0	73.65	0	0	12.2
2015	7	2	19	44	8	34	0	0	0	0	0	0	0	73.65	0	0	12.2
2015	7	2	19	54	8	34	0	0	0	0	0	0	0	73.67	0	0	12.2
2015	7	2	20	4	8	34	0	0	0	0	0	0	0	73.67	0	0	12.2
2015	7	2	20	14	8	34	0	0	0	0	0	0	0	73.69	0	0	12.2
2015	7	2	20	24	8	34	0	0	0	0	0	0	0	73.71	0	0	12.2
2015	7	2	20	34	8	34	0	0	0	0	0	0	0	73.72	0	0	12.2
2015	7	2	20	44	8	33	0	0	0	0	0	0	0	73.71	0	0	12.2
2015	7	2	20	54	8	34	0	0	0	0	0	0	0	73.72	0	0	12.2
2015	7	2	21	4	8	35	0	0	0	0	0	0	0	73.74	0	0	12.2
2015	7	2	21	14	8	34	0	0	0	0	0	0	0	73.76	0	0	12.2
2015	7	2	21	24	8	34	0	0	0	0	0	0	0	73.76	0	0	12.2
2015	7	2	21	34	8	35	0	0	0	0	0	0	0	73.76	0	0	12.2
2015	7	2	21	44	8	34	0	0	0	0	0	0	0	73.76	0	0	12.2
2015	7	2	21	54	8	34	0	0	0	0	0	0	0	73.78	0	0	12.2
2015	7	2	22	4	8	33	0	0	0	0	0	0	0	73.76	0	0	12.2
2015	7	2	22	14	8	35	0	0	0	0	0	0	0	73.78	0	0	12.2
2015	7	2	22	24	8	34	0	0	0	0	0	0	0	73.78	0	0	12.2
2015	7	2	22	34	8	34	0	0	0	0	0	0	0	73.78	0	0	12.2
2015	7	2	22	44	8	34	0	0	0	0	0	0	0	73.78	0	0	12.2
2015	7	2	22	54	8	34	0	0	0	0	0	0	0	73.78	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	2	23	4	8	34		0	0	0	0	0	0	73.78	0	0	12.2
2015	7	2	23	14	8	34		0	0	0	0	0	0	73.78	0	0	12.2
2015	7	2	23	24	8	34		0	0	0	0	0	0	73.76	0	0	12.2
2015	7	2	23	34	8	34		0	0	0	0	0	0	73.76	0	0	12
2015	7	2	23	44	8	34		0	0	0	0	0	0	73.76	0	0	12.2
2015	7	2	23	54	8	34		0	0	0	0	0	0	73.76	0	0	12
2015	7	3	0	4	8	34		0	0	0	0	0	0	73.78	0	0	12
2015	7	3	0	14	8	33		0	0	0	0	0	0	73.76	0	0	12
2015	7	3	0	24	8	34		0	0	0	0	0	0	73.76	0	0	12
2015	7	3	0	34	8	34		0	0	0	0	0	0	73.74	0	0	12
2015	7	3	0	44	8	33		0	0	0	0	0	0	73.74	0	0	12
2015	7	3	0	54	8	34		0	0	0	0	0	0	73.72	0	0	12
2015	7	3	1	4	8	35		0	0	0	0	0	0	73.71	0	0	12
2015	7	3	1	14	8	33		0	0	0	0	0	0	73.71	0	0	12
2015	7	3	1	24	8	33		0	0	0	0	0	0	73.69	0	0	12
2015	7	3	1	34	8	34		0	0	0	0	0	0	73.67	0	0	12
2015	7	3	1	44	8	34		0	0	0	0	0	0	73.65	0	0	12
2015	7	3	1	54	8	34		0	0	0	0	0	0	73.63	0	0	12
2015	7	3	2	4	8	34		0	0	0	0	0	0	73.62	0	0	12
2015	7	3	2	14	8	34		0	0	0	0	0	0	73.58	0	0	12
2015	7	3	2	24	8	34		0	0	0	0	0	0	73.58	0	0	12
2015	7	3	2	34	8	34		0	0	0	0	0	0	73.56	0	0	12
2015	7	3	2	44	8	34		0	0	0	0	0	0	73.53	0	0	12
2015	7	3	2	54	8	33		0	0	0	0	0	0	73.49	0	0	12
2015	7	3	3	4	8	34		0	0	0	0	0	0	73.47	0	0	12
2015	7	3	3	14	8	33		0	0	0	0	0	0	73.44	0	0	12
2015	7	3	3	24	8	34		0	0	0	0	0	0	73.42	0	0	12
2015	7	3	3	34	8	34		0	0	0	0	0	0	73.4	0	0	12
2015	7	3	3	44	8	34		0	0	0	0	0	0	73.35	0	0	12
2015	7	3	3	54	8	34		0	0	0	0	0	0	73.33	0	0	12
2015	7	3	4	4	8	35		0	0	0	0	0	0	73.31	0	0	12
2015	7	3	4	14	8	34		0	0	0	0	0	0	73.27	0	0	12
2015	7	3	4	24	8	34		0	0	0	0	0	0	73.26	0	0	12
2015	7	3	4	34	8	34		0	0	0	0	0	0	73.24	0	0	12
2015	7	3	4	44	8	34		0	0	0	0	0	0	73.2	0	0	12
2015	7	3	4	54	8	34		0	0	0	0	0	0	73.18	0	0	12
2015	7	3	5	4	8	34		0	0	0	0	0	0	73.15	0	0	12
2015	7	3	5	14	8	34		0	0	0	0	0	0	73.13	0	0	12
2015	7	3	5	24	8	34		0	0	0	0	0	0	73.11	0	0	12
2015	7	3	5	34	8	34		0	0	0	0	0	0	73.08	0	0	12
2015	7	3	5	44	8	34		0	0	0	0	0	0	73.04	0	0	12
2015	7	3	5	54	8	33		0	0	0	0	0	0	73.02	0	0	12
2015	7	3	6	4	8	34		0	0	0	0	0	0	72.99	0	0	12
2015	7	3	6	14	8	33		0	0	0	0	0	0	72.97	0	0	12
2015	7	3	6	24	8	34		0	0	0	0	0	0	72.95	0	0	12
2015	7	3	6	34	8	33		0	0	0	0	0	0	72.93	0	0	12
2015	7	3	6	44	8	34		0	0	0	0	0	0	72.9	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	3	6	54	8	34		0	0	0	0	0	0	72.88	0	0	12.2
2015	7	3	7	4	8	34		0	0	0	0	0	0	72.86	0	0	12.2
2015	7	3	7	14	8	34		0	0	0	0	0	0	72.86	0	0	12.2
2015	7	3	7	24	8	34		0	0	0	0	0	0	72.88	0	0	12.4
2015	7	3	7	34	8	34		0	0	0	0	0	0	72.86	0	0	12.4
2015	7	3	7	44	8	34		0	0	0	0	0	0	72.86	0	0	12.4
2015	7	3	7	54	8	34		0	0	0	0	0	0	72.86	0	0	12.6
2015	7	3	8	4	8	34		0	0	0	0	0	0	72.88	0	0	12.6
2015	7	3	8	14	8	34		0	0	0	0	0	0	72.88	0	0	12.6
2015	7	3	8	24	8	34		0	0	0	0	0	0	72.88	0	0	12.8
2015	7	3	8	34	8	34		0	0	0	0	0	0	72.9	0	0	12.8
2015	7	3	8	44	8	34		0	0	0	0	0	0	72.91	0	0	12.8
2015	7	3	8	54	8	34		0	0	0	0	0	0	72.95	0	0	12.8
2015	7	3	9	4	8	34		0	0	0	0	0	0	72.95	0	0	12.8
2015	7	3	9	14	8	34		0	0	0	0	0	0	72.95	0	0	12.8
2015	7	3	9	24	8	34		0	0	0	0	0	0	72.95	0	0	12.8
2015	7	3	9	34	8	35		0	0	0	0	0	0	72.99	0	0	13
2015	7	3	9	44	8	34		0	0	0	0	0	0	73.02	0	0	13.2
2015	7	3	9	54	8	34		0	0	0	0	0	0	73.06	0	0	13.2
2015	7	3	10	4	8	34		0	0	0	0	0	0	73.11	0	0	13.2
2015	7	3	10	14	8	34		0	0	0	0	0	0	73.13	0	0	13.2
2015	7	3	10	24	8	34		0	0	0	0	0	0	73.15	0	0	13.2
2015	7	3	10	34	8	34		0	0	0	0	0	0	73.08	0	0	13
2015	7	3	10	44	8	34		0	0	0	0	0	0	73.13	0	0	13
2015	7	3	10	54	8	34		0	0	0	0	0	0	73.18	0	0	13
2015	7	3	11	4	8	35		0	0	0	0	0	0	73.24	0	0	13
2015	7	3	11	14	8	35		0	0	0	0	0	0	73.24	0	0	13
2015	7	3	11	24	8	34		0	0	0	0	0	0	73.31	0	0	13
2015	7	3	11	34	8	34		0	0	0	0	0	0	73.35	0	0	13
2015	7	3	11	44	8	34		0	0	0	0	0	0	73.35	0	0	13
2015	7	3	11	54	8	34		0	0	0	0	0	0	73.36	0	0	13
2015	7	3	12	4	8	34		0	0	0	0	0	0	73.38	0	0	13
2015	7	3	12	14	8	34		0	0	0	0	0	0	73.42	0	0	13.2
2015	7	3	12	24	8	34		0	0	0	0	0	0	73.49	0	0	13.2
2015	7	3	12	34	8	34		0	0	0	0	0	0	73.49	0	0	13.2
2015	7	3	12	44	8	34		0	0	0	0	0	0	73.53	0	0	13.2
2015	7	3	12	54	8	34		0	0	0	0	0	0	73.54	0	0	13.2
2015	7	3	13	4	8	34		0	0	0	0	0	0	73.56	0	0	13.2
2015	7	3	13	14	8	34		0	0	0	0	0	0	73.58	0	0	13.2
2015	7	3	13	24	8	33		0	0	0	0	0	0	73.6	0	0	13.2
2015	7	3	13	34	8	34		0	0	0	0	0	0	73.62	0	0	13.2
2015	7	3	13	44	8	34		0	0	0	0	0	0	73.63	0	0	13.2
2015	7	3	13	54	8	34		0	0	0	0	0	0	73.62	0	0	13.2
2015	7	3	14	4	8	33		0	0	0	0	0	0	73.65	0	0	13.2
2015	7	3	14	14	8	34		0	0	0	0	0	0	73.62	0	0	13.2
2015	7	3	14	24	8	34		0	0	0	0	0	0	73.56	0	0	13.2
2015	7	3	14	34	8	34		0	0	0	0	0	0	73.62	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	3	14	44	8	34		0	0	0	0	0	0	73.6	0	0	13
2015	7	3	14	54	8	34		0	0	0	0	0	0	73.62	0	0	13
2015	7	3	15	4	8	34		0	0	0	0	0	0	73.6	0	0	13
2015	7	3	15	14	8	34		0	0	0	0	0	0	73.62	0	0	13
2015	7	3	15	24	8	34		0	0	0	0	0	0	73.6	0	0	13
2015	7	3	15	34	8	33		0	0	0	0	0	0	73.58	0	0	13
2015	7	3	15	44	8	34		0	0	0	0	0	0	73.58	0	0	13
2015	7	3	15	54	8	34		0	0	0	0	0	0	73.58	0	0	13
2015	7	3	16	4	8	34		0	0	0	0	0	0	73.58	0	0	13
2015	7	3	16	14	8	34		0	0	0	0	0	0	73.63	0	0	13
2015	7	3	16	24	8	33		0	0	0	0	0	0	73.58	0	0	13
2015	7	3	16	34	8	34		0	0	0	0	0	0	73.6	0	0	13
2015	7	3	16	44	8	34		0	0	0	0	0	0	73.6	0	0	13.2
2015	7	3	16	54	8	34		0	0	0	0	0	0	73.6	0	0	13.2
2015	7	3	17	4	8	34		0	0	0	0	0	0	73.62	0	0	13.2
2015	7	3	17	14	8	33		0	0	0	0	0	0	73.63	0	0	13.2
2015	7	3	17	24	8	33		0	0	0	0	0	0	73.63	0	0	13.2
2015	7	3	17	34	8	35		0	0	0	0	0	0	73.65	0	0	13.2
2015	7	3	17	44	8	33		0	0	0	0	0	0	73.67	0	0	13.2
2015	7	3	17	54	8	35		0	0	0	0	0	0	73.69	0	0	13.2
2015	7	3	18	4	8	34		0	0	0	0	0	0	73.72	0	0	13.2
2015	7	3	18	14	8	34		0	0	0	0	0	0	73.74	0	0	13
2015	7	3	18	24	8	33		0	0	0	0	0	0	73.76	0	0	13.2
2015	7	3	18	34	8	33		0	0	0	0	0	0	73.78	0	0	12.6
2015	7	3	18	44	8	34		0	0	0	0	0	0	73.8	0	0	12.2
2015	7	3	18	54	8	34		0	0	0	0	0	0	73.81	0	0	12.2
2015	7	3	19	4	8	33		0	0	0	0	0	0	73.85	0	0	12.2
2015	7	3	19	14	8	34		0	0	0	0	0	0	73.87	0	0	12.2
2015	7	3	19	24	8	34		0	0	0	0	0	0	73.9	0	0	12.2
2015	7	3	19	34	8	34		0	0	0	0	0	0	73.92	0	0	12.2
2015	7	3	19	44	8	33		0	0	0	0	0	0	73.96	0	0	12.2
2015	7	3	19	54	8	34		0	0	0	0	0	0	73.98	0	0	12.2
2015	7	3	20	4	8	34		0	0	0	0	0	0	74.01	0	0	12.2
2015	7	3	20	14	8	34		0	0	0	0	0	0	74.01	0	0	12.2
2015	7	3	20	24	8	34		0	0	0	0	0	0	74.05	0	0	12.2
2015	7	3	20	34	8	34		0	0	0	0	0	0	74.08	0	0	12.2
2015	7	3	20	44	8	34		0	0	0	0	0	0	74.08	0	0	12.2
2015	7	3	20	54	8	34		0	0	0	0	0	0	74.1	0	0	12.2
2015	7	3	21	4	8	34		0	0	0	0	0	0	74.12	0	0	12.2
2015	7	3	21	14	8	34		0	0	0	0	0	0	74.14	0	0	12.2
2015	7	3	21	24	8	33		0	0	0	0	0	0	74.16	0	0	12.2
2015	7	3	21	34	8	34		0	0	0	0	0	0	74.16	0	0	12.2
2015	7	3	21	44	8	34		0	0	0	0	0	0	74.17	0	0	12.2
2015	7	3	21	54	8	34		0	0	0	0	0	0	74.19	0	0	12.2
2015	7	3	22	4	8	34		0	0	0	0	0	0	74.19	0	0	12.2
2015	7	3	22	14	8	34		0	0	0	0	0	0	74.19	0	0	12.2
2015	7	3	22	24	8	34		0	0	0	0	0	0	74.19	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	3	22	34	8	34		0	0	0	0	0	0	74.19	0	0	12.2
2015	7	3	22	44	8	34		0	0	0	0	0	0	74.21	0	0	12.2
2015	7	3	22	54	8	34		0	0	0	0	0	0	74.19	0	0	12.2
2015	7	3	23	4	8	33		0	0	0	0	0	0	74.19	0	0	12.2
2015	7	3	23	14	8	34		0	0	0	0	0	0	74.19	0	0	12.2
2015	7	3	23	24	8	35		0	0	0	0	0	0	74.19	0	0	12.2
2015	7	3	23	34	8	33		0	0	0	0	0	0	74.17	0	0	12
2015	7	3	23	44	8	34		0	0	0	0	0	0	74.16	0	0	12
2015	7	3	23	54	8	34		0	0	0	0	0	0	74.16	0	0	12
2015	7	4	0	4	8	35		0	0	0	0	0	0	74.14	0	0	12
2015	7	4	0	14	8	33		0	0	0	0	0	0	74.12	0	0	12
2015	7	4	0	24	8	33		0	0	0	0	0	0	74.12	0	0	12
2015	7	4	0	34	8	34		0	0	0	0	0	0	74.1	0	0	12
2015	7	4	0	44	8	34		0	0	0	0	0	0	74.07	0	0	12
2015	7	4	0	54	8	34		0	0	0	0	0	0	74.05	0	0	12
2015	7	4	1	4	8	34		0	0	0	0	0	0	74.03	0	0	12
2015	7	4	1	14	8	34		0	0	0	0	0	0	74.01	0	0	12
2015	7	4	1	24	8	34		0	0	0	0	0	0	73.98	0	0	12
2015	7	4	1	34	8	34		0	0	0	0	0	0	73.96	0	0	12
2015	7	4	1	44	8	33		0	0	0	0	0	0	73.9	0	0	12
2015	7	4	1	54	8	34		0	0	0	0	0	0	73.89	0	0	12
2015	7	4	2	4	8	34		0	0	0	0	0	0	73.85	0	0	12
2015	7	4	2	14	8	35		0	0	0	0	0	0	73.83	0	0	12
2015	7	4	2	24	8	33		0	0	0	0	0	0	73.8	0	0	12
2015	7	4	2	34	8	34		0	0	0	0	0	0	73.78	0	0	12
2015	7	4	2	44	8	34		0	0	0	0	0	0	73.74	0	0	12
2015	7	4	2	54	8	34		0	0	0	0	0	0	73.71	0	0	12
2015	7	4	3	4	8	34		0	0	0	0	0	0	73.67	0	0	12
2015	7	4	3	14	8	34		0	0	0	0	0	0	73.65	0	0	12
2015	7	4	3	24	8	34		0	0	0	0	0	0	73.62	0	0	12
2015	7	4	3	34	8	34		0	0	0	0	0	0	73.58	0	0	12
2015	7	4	3	44	8	35		0	0	0	0	0	0	73.54	0	0	12
2015	7	4	3	54	8	34		0	0	0	0	0	0	73.53	0	0	12
2015	7	4	4	4	8	34		0	0	0	0	0	0	73.49	0	0	12
2015	7	4	4	14	8	34		0	0	0	0	0	0	73.47	0	0	12
2015	7	4	4	24	8	34		0	0	0	0	0	0	73.44	0	0	12
2015	7	4	4	34	8	34		0	0	0	0	0	0	73.4	0	0	12
2015	7	4	4	44	8	34		0	0	0	0	0	0	73.38	0	0	12
2015	7	4	4	54	8	34		0	0	0	0	0	0	73.35	0	0	12
2015	7	4	5	4	8	34		0	0	0	0	0	0	73.33	0	0	12
2015	7	4	5	14	8	35		0	0	0	0	0	0	73.31	0	0	12
2015	7	4	5	24	8	34		0	0	0	0	0	0	73.27	0	0	12
2015	7	4	5	34	8	34		0	0	0	0	0	0	73.24	0	0	12
2015	7	4	5	44	8	34		0	0	0	0	0	0	73.22	0	0	12
2015	7	4	5	54	8	34		0	0	0	0	0	0	73.18	0	0	12
2015	7	4	6	4	8	34		0	0	0	0	0	0	73.17	0	0	12
2015	7	4	6	14	8	34		0	0	0	0	0	0	73.15	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	4	6	24	8	34		0	0	0	0	0	0	73.11	0	0	12
2015	7	4	6	34	8	34		0	0	0	0	0	0	73.11	0	0	12
2015	7	4	6	44	8	35		0	0	0	0	0	0	73.08	0	0	12
2015	7	4	6	54	8	34		0	0	0	0	0	0	73.06	0	0	12
2015	7	4	7	4	8	34		0	0	0	0	0	0	73.04	0	0	12
2015	7	4	7	14	8	34		0	0	0	0	0	0	73.02	0	0	12
2015	7	4	7	24	8	34		0	0	0	0	0	0	73	0	0	12
2015	7	4	7	34	8	33		0	0	0	0	0	0	72.99	0	0	12
2015	7	4	7	44	8	34		0	0	0	0	0	0	72.97	0	0	12
2015	7	4	7	54	8	34		0	0	0	0	0	0	72.97	0	0	12
2015	7	4	8	4	8	34		0	0	0	0	0	0	72.93	0	0	12
2015	7	4	8	14	8	34		0	0	0	0	0	0	72.93	0	0	12
2015	7	4	8	24	8	34		0	0	0	0	0	0	72.93	0	0	12.2
2015	7	4	8	34	8	34		0	0	0	0	0	0	72.93	0	0	12.2
2015	7	4	8	44	8	34		0	0	0	0	0	0	72.91	0	0	12.2
2015	7	4	8	54	8	34		0	0	0	0	0	0	72.91	0	0	12.4
2015	7	4	9	4	8	34		0	0	0	0	0	0	72.9	0	0	12.2
2015	7	4	9	14	8	34		0	0	0	0	0	0	72.9	0	0	12.4
2015	7	4	9	24	8	34		0	0	0	0	0	0	72.9	0	0	12.4
2015	7	4	9	34	8	34		0	0	0	0	0	0	72.9	0	0	12.4
2015	7	4	9	44	8	34		0	0	0	0	0	0	72.93	0	0	12.6
2015	7	4	9	54	8	34		0	0	0	0	0	0	72.97	0	0	12.8
2015	7	4	10	4	8	34		0	0	0	0	0	0	73.06	0	0	13
2015	7	4	10	14	8	35		0	0	0	0	0	0	73.04	0	0	12.8
2015	7	4	10	24	8	34		0	0	0	0	0	0	72.99	0	0	12.6
2015	7	4	10	34	8	34		0	0	0	0	0	0	73.02	0	0	12.8
2015	7	4	10	44	8	34		0	0	0	0	0	0	73.18	0	0	13.2
2015	7	4	10	54	8	33		0	0	0	0	0	0	73.22	0	0	13.2
2015	7	4	11	4	8	34		0	0	0	0	0	0	73.18	0	0	13.2
2015	7	4	11	14	8	33		0	0	0	0	0	0	73.31	0	0	13.2
2015	7	4	11	24	8	33		0	0	0	0	0	0	73.36	0	0	13
2015	7	4	11	34	8	34		0	0	0	0	0	0	73.26	0	0	13
2015	7	4	11	44	8	34		0	0	0	0	0	0	73.17	0	0	13
2015	7	4	11	54	8	34		0	0	0	0	0	0	73.26	0	0	13
2015	7	4	12	4	8	34		0	0	0	0	0	0	73.35	0	0	13
2015	7	4	12	14	8	35		0	0	0	0	0	0	73.24	0	0	13
2015	7	4	12	24	8	34		0	0	0	0	0	0	73.24	0	0	13
2015	7	4	12	34	8	34		0	0	0	0	0	0	73.27	0	0	13
2015	7	4	12	44	8	34		0	0	0	0	0	0	73.2	0	0	13
2015	7	4	12	54	8	35		0	0	0	0	0	0	73.2	0	0	13
2015	7	4	13	4	8	34		0	0	0	0	0	0	73.22	0	0	13
2015	7	4	13	14	8	34		0	0	0	0	0	0	73.47	0	0	13
2015	7	4	13	24	8	34		0	0	0	0	0	0	73.54	0	0	13
2015	7	4	13	34	8	34		0	0	0	0	0	0	73.35	0	0	13
2015	7	4	13	44	8	34		0	0	0	0	0	0	73.33	0	0	13
2015	7	4	13	54	8	34		0	0	0	0	0	0	73.26	0	0	13
2015	7	4	14	4	8	33		0	0	0	0	0	0	73.22	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	4	14	14	8	34	0	0	0	0	0	0	0	73.24	0	0	13.2
2015	7	4	14	24	8	34	0	0	0	0	0	0	0	73.24	0	0	13.2
2015	7	4	14	34	8	35	0	0	0	0	0	0	0	73.24	0	0	13.2
2015	7	4	14	44	8	34	0	0	0	0	0	0	0	73.33	0	0	13.2
2015	7	4	14	54	8	34	0	0	0	0	0	0	0	73.27	0	0	13.2
2015	7	4	15	4	8	35	0	0	0	0	0	0	0	73.22	0	0	13.2
2015	7	4	15	14	8	34	0	0	0	0	0	0	0	73.18	0	0	13.2
2015	7	4	15	24	8	34	0	0	0	0	0	0	0	73.17	0	0	13.2
2015	7	4	15	34	8	34	0	0	0	0	0	0	0	73.18	0	0	13.2
2015	7	4	15	44	8	34	0	0	0	0	0	0	0	73.17	0	0	13.2
2015	7	4	15	54	8	34	0	0	0	0	0	0	0	73.18	0	0	13.2
2015	7	4	16	4	8	34	0	0	0	0	0	0	0	73.13	0	0	13.2
2015	7	4	16	14	8	34	0	0	0	0	0	0	0	73.11	0	0	13
2015	7	4	16	24	8	34	0	0	0	0	0	0	0	73.06	0	0	13.2
2015	7	4	16	34	8	35	0	0	0	0	0	0	0	73.02	0	0	13
2015	7	4	16	44	8	34	0	0	0	0	0	0	0	72.99	0	0	12.6
2015	7	4	16	54	8	34	0	0	0	0	0	0	0	72.95	0	0	12.2
2015	7	4	17	4	8	34	0	0	0	0	0	0	0	72.91	0	0	12.2
2015	7	4	17	14	8	34	0	0	0	0	0	0	0	72.93	0	0	12.2
2015	7	4	17	24	8	34	0	0	0	0	0	0	0	72.93	0	0	12.2
2015	7	4	17	34	8	34	0	0	0	0	0	0	0	72.95	0	0	12.2
2015	7	4	17	44	8	34	0	0	0	0	0	0	0	72.95	0	0	12.2
2015	7	4	17	54	8	35	0	0	0	0	0	0	0	72.93	0	0	12.2
2015	7	4	18	4	8	34	0	0	0	0	0	0	0	72.91	0	0	12.2
2015	7	4	18	14	8	34	0	0	0	0	0	0	0	72.91	0	0	12.2
2015	7	4	18	24	8	34	0	0	0	0	0	0	0	72.93	0	0	12.2
2015	7	4	18	34	8	35	0	0	0	0	0	0	0	72.93	0	0	12.2
2015	7	4	18	44	8	35	0	0	0	0	0	0	0	72.95	0	0	12.2
2015	7	4	18	54	8	35	0	0	0	0	0	0	0	72.93	0	0	12.2
2015	7	4	19	4	8	34	0	0	0	0	0	0	0	72.93	0	0	12.2
2015	7	4	19	14	8	34	0	0	0	0	0	0	0	72.95	0	0	12.2
2015	7	4	19	24	8	34	0	0	0	0	0	0	0	72.95	0	0	12.2
2015	7	4	19	34	8	33	0	0	0	0	0	0	0	72.95	0	0	12.2
2015	7	4	19	44	8	34	0	0	0	0	0	0	0	72.97	0	0	12.2
2015	7	4	19	54	8	35	0	0	0	0	0	0	0	72.97	0	0	12.2
2015	7	4	20	4	8	34	0	0	0	0	0	0	0	72.99	0	0	12.2
2015	7	4	20	14	8	34	0	0	0	0	0	0	0	73	0	0	12.2
2015	7	4	20	24	8	33	0	0	0	0	0	0	0	72.99	0	0	12.2
2015	7	4	20	34	8	34	0	0	0	0	0	0	0	73	0	0	12.2
2015	7	4	20	44	8	34	0	0	0	0	0	0	0	73	0	0	12.2
2015	7	4	20	54	8	35	0	0	0	0	0	0	0	73	0	0	12.2
2015	7	4	21	4	8	33	0	0	0	0	0	0	0	73	0	0	12.2
2015	7	4	21	14	8	33	0	0	0	0	0	0	0	73	0	0	12.2
2015	7	4	21	24	8	34	0	0	0	0	0	0	0	73	0	0	12.2
2015	7	4	21	34	8	35	0	0	0	0	0	0	0	73	0	0	12
2015	7	4	21	44	8	34	0	0	0	0	0	0	0	72.99	0	0	12.2
2015	7	4	21	54	8	35	0	0	0	0	0	0	0	72.99	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	4	22	4	8	34	0	0	0	0	0	0	0	72.97	0	0	12.2
2015	7	4	22	14	8	34	0	0	0	0	0	0	0	72.97	0	0	12
2015	7	4	22	24	8	34	0	0	0	0	0	0	0	72.95	0	0	12
2015	7	4	22	34	8	33	0	0	0	0	0	0	0	72.91	0	0	12
2015	7	4	22	44	8	34	0	0	0	0	0	0	0	72.9	0	0	12
2015	7	4	22	54	8	34	0	0	0	0	0	0	0	72.88	0	0	12
2015	7	4	23	4	8	34	0	0	0	0	0	0	0	72.86	0	0	12
2015	7	4	23	14	8	35	0	0	0	0	0	0	0	72.84	0	0	12
2015	7	4	23	24	8	34	0	0	0	0	0	0	0	72.81	0	0	12
2015	7	4	23	34	8	34	0	0	0	0	0	0	0	72.79	0	0	12
2015	7	4	23	44	8	34	0	0	0	0	0	0	0	72.77	0	0	12
2015	7	4	23	54	8	34	0	0	0	0	0	0	0	72.73	0	0	12
2015	7	5	0	4	8	34	0	0	0	0	0	0	0	72.7	0	0	12
2015	7	5	0	14	8	34	0	0	0	0	0	0	0	72.68	0	0	12
2015	7	5	0	24	8	34	0	0	0	0	0	0	0	72.64	0	0	12
2015	7	5	0	34	8	34	0	0	0	0	0	0	0	72.61	0	0	12
2015	7	5	0	44	8	33	0	0	0	0	0	0	0	72.57	0	0	12
2015	7	5	0	54	8	34	0	0	0	0	0	0	0	72.54	0	0	12
2015	7	5	1	4	8	34	0	0	0	0	0	0	0	72.5	0	0	12
2015	7	5	1	14	8	34	0	0	0	0	0	0	0	72.45	0	0	12
2015	7	5	1	24	8	34	0	0	0	0	0	0	0	72.43	0	0	12
2015	7	5	1	34	8	34	0	0	0	0	0	0	0	72.39	0	0	12
2015	7	5	1	44	8	34	0	0	0	0	0	0	0	72.36	0	0	12
2015	7	5	1	54	8	34	0	0	0	0	0	0	0	72.3	0	0	12
2015	7	5	2	4	8	33	0	0	0	0	0	0	0	72.25	0	0	12
2015	7	5	2	14	8	34	0	0	0	0	0	0	0	72.21	0	0	12
2015	7	5	2	24	8	35	0	0	0	0	0	0	0	72.18	0	0	12
2015	7	5	2	34	8	34	0	0	0	0	0	0	0	72.14	0	0	12
2015	7	5	2	44	8	35	0	0	0	0	0	0	0	72.09	0	0	12
2015	7	5	2	54	8	34	0	0	0	0	0	0	0	72.05	0	0	12
2015	7	5	3	4	8	34	0	0	0	0	0	0	0	72.01	0	0	12
2015	7	5	3	14	8	34	0	0	0	0	0	0	0	71.98	0	0	12
2015	7	5	3	24	8	35	0	0	0	0	0	0	0	71.92	0	0	12
2015	7	5	3	34	8	35	0	0	0	0	0	0	0	71.89	0	0	12
2015	7	5	3	44	8	35	0	0	0	0	0	0	0	71.85	0	0	12
2015	7	5	3	54	8	34	0	0	0	0	0	0	0	71.8	0	0	12
2015	7	5	4	4	8	34	0	0	0	0	0	0	0	71.74	0	0	12
2015	7	5	4	14	8	34	0	0	0	0	0	0	0	71.71	0	0	12
2015	7	5	4	24	8	34	0	0	0	0	0	0	0	71.67	0	0	12
2015	7	5	4	34	8	35	0	0	0	0	0	0	0	71.64	0	0	11.8
2015	7	5	4	44	8	34	0	0	0	0	0	0	0	71.58	0	0	12
2015	7	5	4	54	8	34	0	0	0	0	0	0	0	71.55	0	0	12
2015	7	5	5	4	8	34	0	0	0	0	0	0	0	71.49	0	0	12
2015	7	5	5	14	8	34	0	0	0	0	0	0	0	71.46	0	0	12
2015	7	5	5	24	8	34	0	0	0	0	0	0	0	71.42	0	0	12
2015	7	5	5	34	8	34	0	0	0	0	0	0	0	71.37	0	0	12
2015	7	5	5	44	8	34	0	0	0	0	0	0	0	71.35	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	5	5	54	8	34	0	0	0	0	0	0	0	71.31	0	0	12
2015	7	5	6	4	8	35	0	0	0	0	0	0	0	71.26	0	0	12
2015	7	5	6	14	8	34	0	0	0	0	0	0	0	71.22	0	0	12
2015	7	5	6	24	8	34	0	0	0	0	0	0	0	71.19	0	0	12
2015	7	5	6	34	8	34	0	0	0	0	0	0	0	71.15	0	0	12
2015	7	5	6	44	8	34	0	0	0	0	0	0	0	71.11	0	0	12
2015	7	5	6	54	8	35	0	0	0	0	0	0	0	71.08	0	0	12
2015	7	5	7	4	8	34	0	0	0	0	0	0	0	71.06	0	0	12.2
2015	7	5	7	14	8	34	0	0	0	0	0	0	0	71.04	0	0	12.2
2015	7	5	7	24	8	35	0	0	0	0	0	0	0	71.02	0	0	12.4
2015	7	5	7	34	8	34	0	0	0	0	0	0	0	71.02	0	0	12.4
2015	7	5	7	44	8	34	0	0	0	0	0	0	0	71.01	0	0	12.6
2015	7	5	7	54	8	35	0	0	0	0	0	0	0	71.01	0	0	12.6
2015	7	5	8	4	8	34	0	0	0	0	0	0	0	71.02	0	0	12.8
2015	7	5	8	14	8	34	0	0	0	0	0	0	0	71.04	0	0	12.8
2015	7	5	8	24	8	34	0	0	0	0	0	0	0	71.04	0	0	12.8
2015	7	5	8	34	8	35	0	0	0	0	0	0	0	71.06	0	0	12.8
2015	7	5	8	44	8	34	0	0	0	0	0	0	0	71.06	0	0	12.8
2015	7	5	8	54	8	35	0	0	0	0	0	0	0	71.1	0	0	13
2015	7	5	9	4	8	34	0	0	0	0	0	0	0	71.1	0	0	13
2015	7	5	9	14	8	34	0	0	0	0	0	0	0	71.13	0	0	13
2015	7	5	9	24	8	34	0	0	0	0	0	0	0	71.17	0	0	13
2015	7	5	9	34	8	34	0	0	0	0	0	0	0	71.19	0	0	13
2015	7	5	9	44	8	34	0	0	0	0	0	0	0	71.22	0	0	13.2
2015	7	5	9	54	8	33	0	0	0	0	0	0	0	71.24	0	0	13
2015	7	5	10	4	8	34	0	0	0	0	0	0	0	71.28	0	0	13
2015	7	5	10	14	8	34	0	0	0	0	0	0	0	71.31	0	0	13
2015	7	5	10	24	8	34	0	0	0	0	0	0	0	71.33	0	0	13
2015	7	5	10	34	8	35	0	0	0	0	0	0	0	71.33	0	0	13
2015	7	5	10	44	8	34	0	0	0	0	0	0	0	71.37	0	0	13
2015	7	5	10	54	8	34	0	0	0	0	0	0	0	71.42	0	0	13
2015	7	5	11	4	8	34	0	0	0	0	0	0	0	71.46	0	0	13
2015	7	5	11	14	8	35	0	0	0	0	0	0	0	71.51	0	0	13
2015	7	5	11	24	8	35	0	0	0	0	0	0	0	71.53	0	0	13
2015	7	5	11	34	8	34	0	0	0	0	0	0	0	71.56	0	0	13
2015	7	5	11	44	8	34	0	0	0	0	0	0	0	71.58	0	0	13
2015	7	5	11	54	8	34	0	0	0	0	0	0	0	71.62	0	0	13.2
2015	7	5	12	4	8	34	0	0	0	0	0	0	0	71.64	0	0	13.2
2015	7	5	12	14	8	35	0	0	0	0	0	0	0	71.65	0	0	13.2
2015	7	5	12	24	8	35	0	0	0	0	0	0	0	71.69	0	0	13.2
2015	7	5	12	34	8	34	0	0	0	0	0	0	0	71.73	0	0	13.2
2015	7	5	12	44	8	34	0	0	0	0	0	0	0	71.74	0	0	13.2
2015	7	5	12	54	8	34	0	0	0	0	0	0	0	71.78	0	0	13.2
2015	7	5	13	4	8	34	0	0	0	0	0	0	0	71.82	0	0	13.2
2015	7	5	13	14	8	34	0	0	0	0	0	0	0	71.87	0	0	13.2
2015	7	5	13	24	8	35	0	0	0	0	0	0	0	71.85	0	0	13.2
2015	7	5	13	34	8	34	0	0	0	0	0	0	0	71.78	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	5	13	44	8	34	0	0	0	0	0	0	0	71.82	0	0	13.2
2015	7	5	13	54	8	34	0	0	0	0	0	0	0	71.65	0	0	13.2
2015	7	5	14	4	8	34	0	0	0	0	0	0	0	71.58	0	0	13.2
2015	7	5	14	14	8	35	0	0	0	0	0	0	0	71.56	0	0	13.2
2015	7	5	14	24	8	34	0	0	0	0	0	0	0	71.55	0	0	13.2
2015	7	5	14	34	8	35	0	0	0	0	0	0	0	71.51	0	0	13
2015	7	5	14	44	8	35	0	0	0	0	0	0	0	71.47	0	0	13.2
2015	7	5	14	54	8	34	0	0	0	0	0	0	0	71.46	0	0	12.6
2015	7	5	15	4	8	35	0	0	0	0	0	0	0	71.44	0	0	12.2
2015	7	5	15	14	8	35	0	0	0	0	0	0	0	71.42	0	0	12.2
2015	7	5	15	24	8	34	0	0	0	0	0	0	0	71.42	0	0	12.2
2015	7	5	15	34	8	34	0	0	0	0	0	0	0	71.4	0	0	12.2
2015	7	5	15	44	8	35	0	0	0	0	0	0	0	71.4	0	0	12.4
2015	7	5	15	54	8	34	0	0	0	0	0	0	0	71.42	0	0	13
2015	7	5	16	4	8	34	0	0	0	0	0	0	0	71.42	0	0	13.4
2015	7	5	16	14	8	34	0	0	0	0	0	0	0	71.47	0	0	13.4
2015	7	5	16	24	8	35	0	0	0	0	0	0	0	71.56	0	0	13.4
2015	7	5	16	34	8	34	0	0	0	0	0	0	0	71.6	0	0	13.4
2015	7	5	16	44	8	34	0	0	0	0	0	0	0	71.56	0	0	13.4
2015	7	5	16	54	8	34	0	0	0	0	0	0	0	71.58	0	0	13.2
2015	7	5	17	4	8	35	0	0	0	0	0	0	0	71.6	0	0	13.2
2015	7	5	17	14	8	35	0	0	0	0	0	0	0	71.62	0	0	13.2
2015	7	5	17	24	8	34	0	0	0	0	0	0	0	71.67	0	0	13.2
2015	7	5	17	34	8	34	0	0	0	0	0	0	0	71.69	0	0	13
2015	7	5	17	44	8	34	0	0	0	0	0	0	0	71.71	0	0	13.2
2015	7	5	17	54	8	34	0	0	0	0	0	0	0	71.73	0	0	13.2
2015	7	5	18	4	8	34	0	0	0	0	0	0	0	71.74	0	0	13
2015	7	5	18	14	8	33	0	0	0	0	0	0	0	71.78	0	0	13
2015	7	5	18	24	8	34	0	0	0	0	0	0	0	71.8	0	0	13
2015	7	5	18	34	8	34	0	0	0	0	0	0	0	71.82	0	0	13
2015	7	5	18	44	8	35	0	0	0	0	0	0	0	71.83	0	0	13
2015	7	5	18	54	8	34	0	0	0	0	0	0	0	71.85	0	0	13
2015	7	5	19	4	8	34	0	0	0	0	0	0	0	71.85	0	0	12.4
2015	7	5	19	14	8	34	0	0	0	0	0	0	0	71.87	0	0	12.2
2015	7	5	19	24	8	34	0	0	0	0	0	0	0	71.87	0	0	12.2
2015	7	5	19	34	8	34	0	0	0	0	0	0	0	71.89	0	0	12.2
2015	7	5	19	44	8	34	0	0	0	0	0	0	0	71.91	0	0	12.2
2015	7	5	19	54	8	34	0	0	0	0	0	0	0	71.92	0	0	12.2
2015	7	5	20	4	8	35	0	0	0	0	0	0	0	71.94	0	0	12.2
2015	7	5	20	14	8	34	0	0	0	0	0	0	0	71.98	0	0	12.2
2015	7	5	20	24	8	34	0	0	0	0	0	0	0	71.98	0	0	12.2
2015	7	5	20	34	8	34	0	0	0	0	0	0	0	72	0	0	12.2
2015	7	5	20	44	8	34	0	0	0	0	0	0	0	72.01	0	0	12.2
2015	7	5	20	54	8	33	0	0	0	0	0	0	0	72.01	0	0	12.2
2015	7	5	21	4	8	34	0	0	0	0	0	0	0	72.01	0	0	12.2
2015	7	5	21	14	8	34	0	0	0	0	0	0	0	72.01	0	0	12.2
2015	7	5	21	24	8	34	0	0	0	0	0	0	0	72.01	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	5	21	34	8	34	0	0	0	0	0	0	0	72.01	0	0	12.2
2015	7	5	21	44	8	34	0	0	0	0	0	0	0	72	0	0	12.2
2015	7	5	21	54	8	34	0	0	0	0	0	0	0	72	0	0	12.2
2015	7	5	22	4	8	34	0	0	0	0	0	0	0	71.98	0	0	12.2
2015	7	5	22	14	8	34	0	0	0	0	0	0	0	71.96	0	0	12.2
2015	7	5	22	24	8	34	0	0	0	0	0	0	0	71.94	0	0	12.2
2015	7	5	22	34	8	34	0	0	0	0	0	0	0	71.91	0	0	12.2
2015	7	5	22	44	8	35	0	0	0	0	0	0	0	71.91	0	0	12.2
2015	7	5	22	54	8	35	0	0	0	0	0	0	0	71.87	0	0	12.2
2015	7	5	23	4	8	34	0	0	0	0	0	0	0	71.85	0	0	12.2
2015	7	5	23	14	8	34	0	0	0	0	0	0	0	71.83	0	0	12.2
2015	7	5	23	24	8	35	0	0	0	0	0	0	0	71.83	0	0	12.2
2015	7	5	23	34	8	35	0	0	0	0	0	0	0	71.8	0	0	12.2
2015	7	5	23	44	8	34	0	0	0	0	0	0	0	71.78	0	0	12.2
2015	7	5	23	54	8	34	0	0	0	0	0	0	0	71.76	0	0	12.2
2015	7	6	0	4	8	34	0	0	0	0	0	0	0	71.74	0	0	12
2015	7	6	0	14	8	34	0	0	0	0	0	0	0	71.73	0	0	12
2015	7	6	0	24	8	34	0	0	0	0	0	0	0	71.71	0	0	12
2015	7	6	0	34	8	35	0	0	0	0	0	0	0	71.69	0	0	12
2015	7	6	0	44	8	34	0	0	0	0	0	0	0	71.67	0	0	12
2015	7	6	0	54	8	34	0	0	0	0	0	0	0	71.65	0	0	12
2015	7	6	1	4	8	34	0	0	0	0	0	0	0	71.62	0	0	12
2015	7	6	1	14	8	34	0	0	0	0	0	0	0	71.62	0	0	12
2015	7	6	1	24	8	35	0	0	0	0	0	0	0	71.6	0	0	12
2015	7	6	1	34	8	34	0	0	0	0	0	0	0	71.58	0	0	12
2015	7	6	1	44	8	35	0	0	0	0	0	0	0	71.53	0	0	12
2015	7	6	1	54	8	33	0	0	0	0	0	0	0	71.51	0	0	12
2015	7	6	2	4	8	35	0	0	0	0	0	0	0	71.47	0	0	12
2015	7	6	2	14	8	34	0	0	0	0	0	0	0	71.44	0	0	12
2015	7	6	2	24	8	34	0	0	0	0	0	0	0	71.42	0	0	12
2015	7	6	2	34	8	34	0	0	0	0	0	0	0	71.38	0	0	12
2015	7	6	2	44	8	34	0	0	0	0	0	0	0	71.35	0	0	12
2015	7	6	2	54	8	34	0	0	0	0	0	0	0	71.29	0	0	12
2015	7	6	3	4	8	35	0	0	0	0	0	0	0	71.26	0	0	12
2015	7	6	3	14	8	34	0	0	0	0	0	0	0	71.2	0	0	12
2015	7	6	3	24	8	35	0	0	0	0	0	0	0	71.19	0	0	12
2015	7	6	3	34	8	35	0	0	0	0	0	0	0	71.13	0	0	12
2015	7	6	3	44	8	34	0	0	0	0	0	0	0	71.08	0	0	12
2015	7	6	3	54	8	34	0	0	0	0	0	0	0	71.04	0	0	12
2015	7	6	4	4	8	34	0	0	0	0	0	0	0	70.99	0	0	12
2015	7	6	4	14	8	35	0	0	0	0	0	0	0	70.95	0	0	12
2015	7	6	4	24	8	34	0	0	0	0	0	0	0	70.9	0	0	12
2015	7	6	4	34	8	34	0	0	0	0	0	0	0	70.86	0	0	12
2015	7	6	4	44	8	34	0	0	0	0	0	0	0	70.81	0	0	12
2015	7	6	4	54	8	34	0	0	0	0	0	0	0	70.77	0	0	12
2015	7	6	5	4	8	34	0	0	0	0	0	0	0	70.72	0	0	12
2015	7	6	5	14	8	34	0	0	0	0	0	0	0	70.68	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	6	5	24	8	35	0	0	0	0	0	0	0	70.63	0	0	12
2015	7	6	5	34	8	34	0	0	0	0	0	0	0	70.59	0	0	12
2015	7	6	5	44	8	34	0	0	0	0	0	0	0	70.54	0	0	12
2015	7	6	5	54	8	35	0	0	0	0	0	0	0	70.5	0	0	12
2015	7	6	6	4	8	34	0	0	0	0	0	0	0	70.45	0	0	12
2015	7	6	6	14	8	35	0	0	0	0	0	0	0	70.39	0	0	12
2015	7	6	6	24	8	34	0	0	0	0	0	0	0	70.36	0	0	12
2015	7	6	6	34	8	34	0	0	0	0	0	0	0	70.3	0	0	12
2015	7	6	6	44	8	34	0	0	0	0	0	0	0	70.27	0	0	12
2015	7	6	6	54	8	34	0	0	0	0	0	0	0	70.23	0	0	12.2
2015	7	6	7	4	8	34	0	0	0	0	0	0	0	70.2	0	0	12.2
2015	7	6	7	14	8	35	0	0	0	0	0	0	0	70.2	0	0	12.2
2015	7	6	7	24	8	35	0	0	0	0	0	0	0	70.18	0	0	12.4
2015	7	6	7	34	8	34	0	0	0	0	0	0	0	70.18	0	0	12.4
2015	7	6	7	44	8	34	0	0	0	0	0	0	0	70.16	0	0	12.6
2015	7	6	7	54	8	35	0	0	0	0	0	0	0	70.16	0	0	12.6
2015	7	6	8	4	8	34	0	0	0	0	0	0	0	70.14	0	0	12.6
2015	7	6	8	14	8	35	0	0	0	0	0	0	0	70.16	0	0	12.8
2015	7	6	8	24	8	34	0	0	0	0	0	0	0	70.18	0	0	12.8
2015	7	6	8	34	8	34	0	0	0	0	0	0	0	70.18	0	0	12.8
2015	7	6	8	44	8	35	0	0	0	0	0	0	0	70.2	0	0	12.8
2015	7	6	8	54	8	34	0	0	0	0	0	0	0	70.21	0	0	13
2015	7	6	9	4	8	34	0	0	0	0	0	0	0	70.23	0	0	13
2015	7	6	9	14	8	35	0	0	0	0	0	0	0	70.25	0	0	13
2015	7	6	9	24	8	34	0	0	0	0	0	0	0	70.27	0	0	13.2
2015	7	6	9	34	8	35	0	0	0	0	0	0	0	70.3	0	0	13.2
2015	7	6	9	44	8	35	0	0	0	0	0	0	0	70.32	0	0	13.2
2015	7	6	9	54	8	35	0	0	0	0	0	0	0	70.36	0	0	13
2015	7	6	10	4	8	34	0	0	0	0	0	0	0	70.38	0	0	13
2015	7	6	10	14	8	34	0	0	0	0	0	0	0	70.41	0	0	13
2015	7	6	10	24	8	34	0	0	0	0	0	0	0	70.43	0	0	13
2015	7	6	10	34	8	35	0	0	0	0	0	0	0	70.43	0	0	13
2015	7	6	10	44	8	34	0	0	0	0	0	0	0	70.43	0	0	13
2015	7	6	10	54	8	35	0	0	0	0	0	0	0	70.48	0	0	13
2015	7	6	11	4	8	34	0	0	0	0	0	0	0	70.52	0	0	13
2015	7	6	11	14	8	35	0	0	0	0	0	0	0	70.56	0	0	13
2015	7	6	11	24	8	34	0	0	0	0	0	0	0	70.59	0	0	13
2015	7	6	11	34	8	34	0	0	0	0	0	0	0	70.63	0	0	13
2015	7	6	11	44	8	34	0	0	0	0	0	0	0	70.65	0	0	13
2015	7	6	11	54	8	34	0	0	0	0	0	0	0	70.66	0	0	13.2
2015	7	6	12	4	8	34	0	0	0	0	0	0	0	70.68	0	0	13.2
2015	7	6	12	14	8	35	0	0	0	0	0	0	0	70.74	0	0	13.2
2015	7	6	12	24	8	34	0	0	0	0	0	0	0	70.75	0	0	13.2
2015	7	6	12	34	8	34	0	0	0	0	0	0	0	70.81	0	0	13.2
2015	7	6	12	44	8	34	0	0	0	0	0	0	0	70.75	0	0	13.2
2015	7	6	12	54	8	34	0	0	0	0	0	0	0	70.79	0	0	13.2
2015	7	6	13	4	8	35	0	0	0	0	0	0	0	70.7	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	6	13	14	8	35	0	0	0	0	0	0	0	70.65	0	0	13.2
2015	7	6	13	24	8	34	0	0	0	0	0	0	0	70.65	0	0	13.2
2015	7	6	13	34	8	35	0	0	0	0	0	0	0	70.84	0	0	13.2
2015	7	6	13	44	8	34	0	0	0	0	0	0	0	70.7	0	0	13.2
2015	7	6	13	54	8	34	0	0	0	0	0	0	0	70.66	0	0	13.2
2015	7	6	14	4	8	35	0	0	0	0	0	0	0	70.79	0	0	13.2
2015	7	6	14	14	8	34	0	0	0	0	0	0	0	70.84	0	0	13.2
2015	7	6	14	24	8	34	0	0	0	0	0	0	0	70.88	0	0	13.2
2015	7	6	14	34	8	35	0	0	0	0	0	0	0	70.7	0	0	13.2
2015	7	6	14	44	8	35	0	0	0	0	0	0	0	70.65	0	0	13.2
2015	7	6	14	54	8	35	0	0	0	0	0	0	0	70.63	0	0	13.2
2015	7	6	15	4	8	35	0	0	0	0	0	0	0	70.65	0	0	13.2
2015	7	6	15	14	8	35	0	0	0	0	0	0	0	70.66	0	0	13.2
2015	7	6	15	24	8	34	0	0	0	0	0	0	0	70.66	0	0	13.2
2015	7	6	15	34	8	35	0	0	0	0	0	0	0	70.7	0	0	13.2
2015	7	6	15	44	8	35	0	0	0	0	0	0	0	70.66	0	0	13.2
2015	7	6	15	54	8	34	0	0	0	0	0	0	0	70.65	0	0	13.2
2015	7	6	16	4	8	34	0	0	0	0	0	0	0	70.65	0	0	13.2
2015	7	6	16	14	8	34	0	0	0	0	0	0	0	70.66	0	0	13.2
2015	7	6	16	24	8	35	0	0	0	0	0	0	0	70.66	0	0	13
2015	7	6	16	34	8	34	0	0	0	0	0	0	0	70.66	0	0	12.8
2015	7	6	16	44	8	35	0	0	0	0	0	0	0	70.66	0	0	12.4
2015	7	6	16	54	8	35	0	0	0	0	0	0	0	70.68	0	0	12.2
2015	7	6	17	4	8	34	0	0	0	0	0	0	0	70.68	0	0	12.2
2015	7	6	17	14	8	34	0	0	0	0	0	0	0	70.72	0	0	12.2
2015	7	6	17	24	8	34	0	0	0	0	0	0	0	70.74	0	0	12.2
2015	7	6	17	34	8	34	0	0	0	0	0	0	0	70.75	0	0	12.2
2015	7	6	17	44	8	35	0	0	0	0	0	0	0	70.77	0	0	12.2
2015	7	6	17	54	8	34	0	0	0	0	0	0	0	70.79	0	0	12.2
2015	7	6	18	4	8	34	0	0	0	0	0	0	0	70.81	0	0	12.2
2015	7	6	18	14	8	34	0	0	0	0	0	0	0	70.84	0	0	12.2
2015	7	6	18	24	8	35	0	0	0	0	0	0	0	70.86	0	0	12.2
2015	7	6	18	34	8	34	0	0	0	0	0	0	0	70.88	0	0	12.2
2015	7	6	18	44	8	35	0	0	0	0	0	0	0	70.92	0	0	12.2
2015	7	6	18	54	8	34	0	0	0	0	0	0	0	70.93	0	0	12.2
2015	7	6	19	4	8	35	0	0	0	0	0	0	0	70.95	0	0	12.2
2015	7	6	19	14	8	35	0	0	0	0	0	0	0	70.97	0	0	12.2
2015	7	6	19	24	8	34	0	0	0	0	0	0	0	71.01	0	0	12.2
2015	7	6	19	34	8	35	0	0	0	0	0	0	0	71.04	0	0	12.2
2015	7	6	19	44	8	34	0	0	0	0	0	0	0	71.06	0	0	12.2
2015	7	6	19	54	8	34	0	0	0	0	0	0	0	71.06	0	0	12.2
2015	7	6	20	4	8	34	0	0	0	0	0	0	0	71.1	0	0	12.2
2015	7	6	20	14	8	34	0	0	0	0	0	0	0	71.11	0	0	12.2
2015	7	6	20	24	8	34	0	0	0	0	0	0	0	71.13	0	0	12.2
2015	7	6	20	34	8	35	0	0	0	0	0	0	0	71.13	0	0	12.2
2015	7	6	20	44	8	34	0	0	0	0	0	0	0	71.15	0	0	12.2
2015	7	6	20	54	8	34	0	0	0	0	0	0	0	71.17	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	6	21	4	8	34	0	0	0	0	0	0	0	71.17	0	0	12.2
2015	7	6	21	14	8	34	0	0	0	0	0	0	0	71.19	0	0	12.2
2015	7	6	21	24	8	35	0	0	0	0	0	0	0	71.19	0	0	12.2
2015	7	6	21	34	8	34	0	0	0	0	0	0	0	71.2	0	0	12.2
2015	7	6	21	44	8	34	0	0	0	0	0	0	0	71.2	0	0	12.2
2015	7	6	21	54	8	34	0	0	0	0	0	0	0	71.2	0	0	12.2
2015	7	6	22	4	8	34	0	0	0	0	0	0	0	71.2	0	0	12.2
2015	7	6	22	14	8	35	0	0	0	0	0	0	0	71.19	0	0	12.2
2015	7	6	22	24	8	34	0	0	0	0	0	0	0	71.2	0	0	12.2
2015	7	6	22	34	8	34	0	0	0	0	0	0	0	71.19	0	0	12.2
2015	7	6	22	44	8	34	0	0	0	0	0	0	0	71.19	0	0	12.2
2015	7	6	22	54	8	35	0	0	0	0	0	0	0	71.17	0	0	12.2
2015	7	6	23	4	8	34	0	0	0	0	0	0	0	71.17	0	0	12
2015	7	6	23	14	8	34	0	0	0	0	0	0	0	71.17	0	0	12
2015	7	6	23	24	8	34	0	0	0	0	0	0	0	71.15	0	0	12
2015	7	6	23	34	8	34	0	0	0	0	0	0	0	71.15	0	0	12
2015	7	6	23	44	8	35	0	0	0	0	0	0	0	71.13	0	0	12
2015	7	6	23	54	8	35	0	0	0	0	0	0	0	71.13	0	0	12
2015	7	7	0	4	8	34	0	0	0	0	0	0	0	71.11	0	0	12
2015	7	7	0	14	8	34	0	0	0	0	0	0	0	71.11	0	0	12
2015	7	7	0	24	8	34	0	0	0	0	0	0	0	71.1	0	0	12
2015	7	7	0	34	8	35	0	0	0	0	0	0	0	71.1	0	0	12
2015	7	7	0	44	8	35	0	0	0	0	0	0	0	71.08	0	0	12
2015	7	7	0	54	8	34	0	0	0	0	0	0	0	71.06	0	0	12
2015	7	7	1	4	8	35	0	0	0	0	0	0	0	71.06	0	0	12
2015	7	7	1	14	8	35	0	0	0	0	0	0	0	71.06	0	0	12
2015	7	7	1	24	8	34	0	0	0	0	0	0	0	71.04	0	0	12
2015	7	7	1	34	8	34	0	0	0	0	0	0	0	71.02	0	0	12
2015	7	7	1	44	8	34	0	0	0	0	0	0	0	71.02	0	0	12
2015	7	7	1	54	8	34	0	0	0	0	0	0	0	71.01	0	0	12
2015	7	7	2	4	8	35	0	0	0	0	0	0	0	70.99	0	0	12
2015	7	7	2	14	8	34	0	0	0	0	0	0	0	70.99	0	0	12
2015	7	7	2	24	8	35	0	0	0	0	0	0	0	70.95	0	0	12
2015	7	7	2	34	8	33	0	0	0	0	0	0	0	70.95	0	0	12
2015	7	7	2	44	8	35	0	0	0	0	0	0	0	70.93	0	0	12
2015	7	7	2	54	8	34	0	0	0	0	0	0	0	70.92	0	0	12
2015	7	7	3	4	8	34	0	0	0	0	0	0	0	70.9	0	0	12
2015	7	7	3	14	8	34	0	0	0	0	0	0	0	70.88	0	0	12
2015	7	7	3	24	8	34	0	0	0	0	0	0	0	70.84	0	0	12
2015	7	7	3	34	8	34	0	0	0	0	0	0	0	70.84	0	0	12
2015	7	7	3	44	8	35	0	0	0	0	0	0	0	70.81	0	0	12
2015	7	7	3	54	8	34	0	0	0	0	0	0	0	70.77	0	0	12
2015	7	7	4	4	8	35	0	0	0	0	0	0	0	70.75	0	0	12
2015	7	7	4	14	8	34	0	0	0	0	0	0	0	70.72	0	0	12
2015	7	7	4	24	8	34	0	0	0	0	0	0	0	70.68	0	0	12
2015	7	7	4	34	8	34	0	0	0	0	0	0	0	70.65	0	0	12
2015	7	7	4	44	8	34	0	0	0	0	0	0	0	70.63	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	7	4	54	8	35	0	0	0	0	0	0	0	70.59	0	0	12
2015	7	7	5	4	8	35	0	0	0	0	0	0	0	70.56	0	0	12
2015	7	7	5	14	8	35	0	0	0	0	0	0	0	70.52	0	0	12
2015	7	7	5	24	8	34	0	0	0	0	0	0	0	70.48	0	0	12
2015	7	7	5	34	8	34	0	0	0	0	0	0	0	70.47	0	0	12
2015	7	7	5	44	8	34	0	0	0	0	0	0	0	70.43	0	0	12
2015	7	7	5	54	8	35	0	0	0	0	0	0	0	70.39	0	0	12
2015	7	7	6	4	8	34	0	0	0	0	0	0	0	70.36	0	0	12
2015	7	7	6	14	8	34	0	0	0	0	0	0	0	70.32	0	0	12
2015	7	7	6	24	8	34	0	0	0	0	0	0	0	70.29	0	0	12
2015	7	7	6	34	8	34	0	0	0	0	0	0	0	70.25	0	0	12
2015	7	7	6	44	8	35	0	0	0	0	0	0	0	70.21	0	0	12
2015	7	7	6	54	8	34	0	0	0	0	0	0	0	70.2	0	0	12
2015	7	7	7	4	8	35	0	0	0	0	0	0	0	70.16	0	0	12.2
2015	7	7	7	14	8	34	0	0	0	0	0	0	0	70.16	0	0	12.2
2015	7	7	7	24	8	35	0	0	0	0	0	0	0	70.14	0	0	12.2
2015	7	7	7	34	8	34	0	0	0	0	0	0	0	70.14	0	0	12.4
2015	7	7	7	44	8	34	0	0	0	0	0	0	0	70.12	0	0	12.4
2015	7	7	7	54	8	35	0	0	0	0	0	0	0	70.14	0	0	12.6
2015	7	7	8	4	8	34	0	0	0	0	0	0	0	70.12	0	0	12.6
2015	7	7	8	14	8	35	0	0	0	0	0	0	0	70.12	0	0	12.6
2015	7	7	8	24	8	35	0	0	0	0	0	0	0	70.14	0	0	12.8
2015	7	7	8	34	8	34	0	0	0	0	0	0	0	70.16	0	0	12.8
2015	7	7	8	44	8	35	0	0	0	0	0	0	0	70.16	0	0	12.8
2015	7	7	8	54	8	34	0	0	0	0	0	0	0	70.18	0	0	12.8
2015	7	7	9	4	8	35	0	0	0	0	0	0	0	70.2	0	0	12.8
2015	7	7	9	14	8	35	0	0	0	0	0	0	0	70.23	0	0	13
2015	7	7	9	24	8	35	0	0	0	0	0	0	0	70.23	0	0	13
2015	7	7	9	34	8	34	0	0	0	0	0	0	0	70.27	0	0	13
2015	7	7	9	44	8	34	0	0	0	0	0	0	0	70.29	0	0	13
2015	7	7	9	54	8	35	0	0	0	0	0	0	0	70.32	0	0	13
2015	7	7	10	4	8	35	0	0	0	0	0	0	0	70.32	0	0	13
2015	7	7	10	14	8	35	0	0	0	0	0	0	0	70.36	0	0	13
2015	7	7	10	24	8	34	0	0	0	0	0	0	0	70.36	0	0	13
2015	7	7	10	34	8	34	0	0	0	0	0	0	0	70.38	0	0	13
2015	7	7	10	44	8	34	0	0	0	0	0	0	0	70.39	0	0	13
2015	7	7	10	54	8	35	0	0	0	0	0	0	0	70.45	0	0	13
2015	7	7	11	4	8	35	0	0	0	0	0	0	0	70.5	0	0	13.2
2015	7	7	11	14	8	34	0	0	0	0	0	0	0	70.56	0	0	13.2
2015	7	7	11	24	8	34	0	0	0	0	0	0	0	70.56	0	0	13.2
2015	7	7	11	34	8	34	0	0	0	0	0	0	0	70.57	0	0	13.2
2015	7	7	11	44	8	34	0	0	0	0	0	0	0	70.59	0	0	13.2
2015	7	7	11	54	8	35	0	0	0	0	0	0	0	70.63	0	0	13.2
2015	7	7	12	4	8	35	0	0	0	0	0	0	0	70.65	0	0	13.2
2015	7	7	12	14	8	35	0	0	0	0	0	0	0	70.68	0	0	13.2
2015	7	7	12	24	8	35	0	0	0	0	0	0	0	70.7	0	0	13.2
2015	7	7	12	34	8	34	0	0	0	0	0	0	0	70.72	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	7	12	44	8	34	0	0	0	0	0	0	0	70.74	0	0	13.2
2015	7	7	12	54	8	35	0	0	0	0	0	0	0	70.77	0	0	13.2
2015	7	7	13	4	8	34	0	0	0	0	0	0	0	70.79	0	0	13.2
2015	7	7	13	14	8	35	0	0	0	0	0	0	0	70.83	0	0	13.2
2015	7	7	13	24	8	35	0	0	0	0	0	0	0	70.83	0	0	13.2
2015	7	7	13	34	8	34	0	0	0	0	0	0	0	70.84	0	0	13.2
2015	7	7	13	44	8	34	0	0	0	0	0	0	0	70.84	0	0	13.2
2015	7	7	13	54	8	34	0	0	0	0	0	0	0	70.86	0	0	13.2
2015	7	7	14	4	8	35	0	0	0	0	0	0	0	70.88	0	0	13.2
2015	7	7	14	14	8	34	0	0	0	0	0	0	0	70.86	0	0	13.2
2015	7	7	14	24	8	34	0	0	0	0	0	0	0	70.88	0	0	13.2
2015	7	7	14	34	8	34	0	0	0	0	0	0	0	70.9	0	0	13.2
2015	7	7	14	44	8	34	0	0	0	0	0	0	0	70.9	0	0	13.2
2015	7	7	14	54	8	35	0	0	0	0	0	0	0	70.88	0	0	13.2
2015	7	7	15	4	8	35	0	0	0	0	0	0	0	70.88	0	0	13.2
2015	7	7	15	14	8	35	0	0	0	0	0	0	0	70.9	0	0	13.2
2015	7	7	15	24	8	35	0	0	0	0	0	0	0	70.9	0	0	13.2
2015	7	7	15	34	8	33	0	0	0	0	0	0	0	70.88	0	0	13.2
2015	7	7	15	44	8	34	0	0	0	0	0	0	0	70.9	0	0	13.2
2015	7	7	15	54	8	34	0	0	0	0	0	0	0	70.9	0	0	13.2
2015	7	7	16	4	8	35	0	0	0	0	0	0	0	70.88	0	0	13.2
2015	7	7	16	14	8	35	0	0	0	0	0	0	0	70.88	0	0	13.2
2015	7	7	16	24	8	35	0	0	0	0	0	0	0	70.9	0	0	13.2
2015	7	7	16	34	8	35	0	0	0	0	0	0	0	70.88	0	0	13.2
2015	7	7	16	44	8	34	0	0	0	0	0	0	0	70.88	0	0	13.2
2015	7	7	16	54	8	35	0	0	0	0	0	0	0	70.88	0	0	13.2
2015	7	7	17	4	8	34	0	0	0	0	0	0	0	70.88	0	0	13.2
2015	7	7	17	14	8	34	0	0	0	0	0	0	0	70.88	0	0	13.2
2015	7	7	17	24	8	34	0	0	0	0	0	0	0	70.86	0	0	13.2
2015	7	7	17	34	8	34	0	0	0	0	0	0	0	70.86	0	0	13
2015	7	7	17	44	8	34	0	0	0	0	0	0	0	70.86	0	0	13.2
2015	7	7	17	54	8	34	0	0	0	0	0	0	0	70.86	0	0	13.2
2015	7	7	18	4	8	34	0	0	0	0	0	0	0	70.88	0	0	13.2
2015	7	7	18	14	8	34	0	0	0	0	0	0	0	70.9	0	0	12.8
2015	7	7	18	24	8	34	0	0	0	0	0	0	0	70.88	0	0	12.2
2015	7	7	18	34	8	35	0	0	0	0	0	0	0	70.9	0	0	12.2
2015	7	7	18	44	8	34	0	0	0	0	0	0	0	70.92	0	0	12.2
2015	7	7	18	54	8	35	0	0	0	0	0	0	0	70.92	0	0	12.2
2015	7	7	19	4	8	35	0	0	0	0	0	0	0	70.93	0	0	12.2
2015	7	7	19	14	8	34	0	0	0	0	0	0	0	70.95	0	0	12.2
2015	7	7	19	24	8	34	0	0	0	0	0	0	0	70.99	0	0	12.2
2015	7	7	19	34	8	34	0	0	0	0	0	0	0	70.99	0	0	12.2
2015	7	7	19	44	8	35	0	0	0	0	0	0	0	71.01	0	0	12.2
2015	7	7	19	54	8	34	0	0	0	0	0	0	0	71.04	0	0	12.2
2015	7	7	20	4	8	34	0	0	0	0	0	0	0	71.04	0	0	12.2
2015	7	7	20	14	8	35	0	0	0	0	0	0	0	71.06	0	0	12.2
2015	7	7	20	24	8	35	0	0	0	0	0	0	0	71.08	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	7	20	34	8	34	0	0	0	0	0	0	0	71.1	0	0	12.2
2015	7	7	20	44	8	35	0	0	0	0	0	0	0	71.11	0	0	12.2
2015	7	7	20	54	8	35	0	0	0	0	0	0	0	71.13	0	0	12.2
2015	7	7	21	4	8	34	0	0	0	0	0	0	0	71.15	0	0	12.2
2015	7	7	21	14	8	34	0	0	0	0	0	0	0	71.17	0	0	12.2
2015	7	7	21	24	8	34	0	0	0	0	0	0	0	71.19	0	0	12.2
2015	7	7	21	34	8	34	0	0	0	0	0	0	0	71.2	0	0	12.2
2015	7	7	21	44	8	34	0	0	0	0	0	0	0	71.22	0	0	12.2
2015	7	7	21	54	8	34	0	0	0	0	0	0	0	71.24	0	0	12.2
2015	7	7	22	4	8	34	0	0	0	0	0	0	0	71.24	0	0	12.2
2015	7	7	22	14	8	34	0	0	0	0	0	0	0	71.26	0	0	12.2
2015	7	7	22	24	8	35	0	0	0	0	0	0	0	71.26	0	0	12.2
2015	7	7	22	34	8	34	0	0	0	0	0	0	0	71.28	0	0	12.2
2015	7	7	22	44	8	34	0	0	0	0	0	0	0	71.28	0	0	12.2
2015	7	7	22	54	8	35	0	0	0	0	0	0	0	71.28	0	0	12.2
2015	7	7	23	4	8	34	0	0	0	0	0	0	0	71.28	0	0	12.2
2015	7	7	23	14	8	35	0	0	0	0	0	0	0	71.26	0	0	12.2
2015	7	7	23	24	8	34	0	0	0	0	0	0	0	71.28	0	0	12.2
2015	7	7	23	34	8	34	0	0	0	0	0	0	0	71.28	0	0	12
2015	7	7	23	44	8	35	0	0	0	0	0	0	0	71.28	0	0	12
2015	7	7	23	54	8	35	0	0	0	0	0	0	0	71.28	0	0	12
2015	7	8	0	4	8	34	0	0	0	0	0	0	0	71.28	0	0	12
2015	7	8	0	14	8	34	0	0	0	0	0	0	0	71.26	0	0	12
2015	7	8	0	24	8	34	0	0	0	0	0	0	0	71.26	0	0	12
2015	7	8	0	34	8	34	0	0	0	0	0	0	0	71.24	0	0	12
2015	7	8	0	44	8	34	0	0	0	0	0	0	0	71.24	0	0	12
2015	7	8	0	54	8	35	0	0	0	0	0	0	0	71.2	0	0	12
2015	7	8	1	4	8	35	0	0	0	0	0	0	0	71.2	0	0	12
2015	7	8	1	14	8	35	0	0	0	0	0	0	0	71.19	0	0	12
2015	7	8	1	24	8	35	0	0	0	0	0	0	0	71.17	0	0	12
2015	7	8	1	34	8	35	0	0	0	0	0	0	0	71.15	0	0	12
2015	7	8	1	44	8	34	0	0	0	0	0	0	0	71.13	0	0	12
2015	7	8	1	54	8	35	0	0	0	0	0	0	0	71.11	0	0	12
2015	7	8	2	4	8	34	0	0	0	0	0	0	0	71.1	0	0	12
2015	7	8	2	14	8	35	0	0	0	0	0	0	0	71.06	0	0	12
2015	7	8	2	24	8	34	0	0	0	0	0	0	0	71.04	0	0	12
2015	7	8	2	34	8	34	0	0	0	0	0	0	0	71.02	0	0	12
2015	7	8	2	44	8	34	0	0	0	0	0	0	0	71.01	0	0	12
2015	7	8	2	54	8	35	0	0	0	0	0	0	0	70.99	0	0	12
2015	7	8	3	4	8	34	0	0	0	0	0	0	0	70.95	0	0	12
2015	7	8	3	14	8	34	0	0	0	0	0	0	0	70.92	0	0	12
2015	7	8	3	24	8	35	0	0	0	0	0	0	0	70.9	0	0	12
2015	7	8	3	34	8	35	0	0	0	0	0	0	0	70.84	0	0	12
2015	7	8	3	44	8	34	0	0	0	0	0	0	0	70.83	0	0	12
2015	7	8	3	54	8	34	0	0	0	0	0	0	0	70.77	0	0	12
2015	7	8	4	4	8	34	0	0	0	0	0	0	0	70.74	0	0	12
2015	7	8	4	14	8	35	0	0	0	0	0	0	0	70.7	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	8	4	24	8	34	0	0	0	0	0	0	0	70.66	0	0	12
2015	7	8	4	34	8	35	0	0	0	0	0	0	0	70.63	0	0	12
2015	7	8	4	44	8	34	0	0	0	0	0	0	0	70.59	0	0	12
2015	7	8	4	54	8	34	0	0	0	0	0	0	0	70.56	0	0	12
2015	7	8	5	4	8	35	0	0	0	0	0	0	0	70.5	0	0	12
2015	7	8	5	14	8	34	0	0	0	0	0	0	0	70.48	0	0	12
2015	7	8	5	24	8	34	0	0	0	0	0	0	0	70.45	0	0	12
2015	7	8	5	34	8	34	0	0	0	0	0	0	0	70.41	0	0	12
2015	7	8	5	44	8	35	0	0	0	0	0	0	0	70.38	0	0	12
2015	7	8	5	54	8	34	0	0	0	0	0	0	0	70.34	0	0	12
2015	7	8	6	4	8	35	0	0	0	0	0	0	0	70.3	0	0	12
2015	7	8	6	14	8	35	0	0	0	0	0	0	0	70.27	0	0	12
2015	7	8	6	24	8	34	0	0	0	0	0	0	0	70.23	0	0	12
2015	7	8	6	34	8	34	0	0	0	0	0	0	0	70.2	0	0	12
2015	7	8	6	44	8	34	0	0	0	0	0	0	0	70.16	0	0	12
2015	7	8	6	54	8	34	0	0	0	0	0	0	0	70.12	0	0	12.2
2015	7	8	7	4	8	35	0	0	0	0	0	0	0	70.09	0	0	12.2
2015	7	8	7	14	8	35	0	0	0	0	0	0	0	70.09	0	0	12.2
2015	7	8	7	24	8	35	0	0	0	0	0	0	0	70.07	0	0	12.4
2015	7	8	7	34	8	35	0	0	0	0	0	0	0	70.07	0	0	12.4
2015	7	8	7	44	8	34	0	0	0	0	0	0	0	70.05	0	0	12.6
2015	7	8	7	54	8	34	0	0	0	0	0	0	0	70.07	0	0	12.6
2015	7	8	8	4	8	35	0	0	0	0	0	0	0	70.07	0	0	12.6
2015	7	8	8	14	8	34	0	0	0	0	0	0	0	70.07	0	0	12.6
2015	7	8	8	24	8	34	0	0	0	0	0	0	0	70.07	0	0	12.8
2015	7	8	8	34	8	35	0	0	0	0	0	0	0	70.09	0	0	12.8
2015	7	8	8	44	8	34	0	0	0	0	0	0	0	70.11	0	0	12.8
2015	7	8	8	54	8	34	0	0	0	0	0	0	0	70.12	0	0	12.8
2015	7	8	9	4	8	34	0	0	0	0	0	0	0	70.09	0	0	12.8
2015	7	8	9	14	8	34	0	0	0	0	0	0	0	70.09	0	0	12.8
2015	7	8	9	24	8	34	0	0	0	0	0	0	0	70.09	0	0	12.8
2015	7	8	9	34	8	34	0	0	0	0	0	0	0	70.12	0	0	13
2015	7	8	9	44	8	35	0	0	0	0	0	0	0	70.2	0	0	13.2
2015	7	8	9	54	8	35	0	0	0	0	0	0	0	70.23	0	0	13.2
2015	7	8	10	4	8	35	0	0	0	0	0	0	0	70.25	0	0	13.2
2015	7	8	10	14	8	34	0	0	0	0	0	0	0	70.29	0	0	13.2
2015	7	8	10	24	8	35	0	0	0	0	0	0	0	70.29	0	0	13.2
2015	7	8	10	34	8	35	0	0	0	0	0	0	0	70.3	0	0	13.2
2015	7	8	10	44	8	34	0	0	0	0	0	0	0	70.36	0	0	13.2
2015	7	8	10	54	8	34	0	0	0	0	0	0	0	70.39	0	0	13.2
2015	7	8	11	4	8	35	0	0	0	0	0	0	0	70.43	0	0	13.2
2015	7	8	11	14	8	34	0	0	0	0	0	0	0	70.48	0	0	13.2
2015	7	8	11	24	8	35	0	0	0	0	0	0	0	70.5	0	0	13.2
2015	7	8	11	34	8	34	0	0	0	0	0	0	0	70.56	0	0	13.2
2015	7	8	11	44	8	34	0	0	0	0	0	0	0	70.56	0	0	13.2
2015	7	8	11	54	8	34	0	0	0	0	0	0	0	70.59	0	0	13.2
2015	7	8	12	4	8	34	0	0	0	0	0	0	0	70.65	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	8	12	14	8	35		0	0	0	0	0	0	70.66	0	0	13.2
2015	7	8	12	24	8	35		0	0	0	0	0	0	70.68	0	0	13.2
2015	7	8	12	34	8	34		0	0	0	0	0	0	70.74	0	0	13.2
2015	7	8	12	44	8	34		0	0	0	0	0	0	70.77	0	0	13.2
2015	7	8	12	54	8	35		0	0	0	0	0	0	70.79	0	0	13.2
2015	7	8	13	4	8	35		0	0	0	0	0	0	70.81	0	0	13.2
2015	7	8	13	14	8	34		0	0	0	0	0	0	70.84	0	0	13.2
2015	7	8	13	24	8	34		0	0	0	0	0	0	70.88	0	0	13.2
2015	7	8	13	34	8	35		0	0	0	0	0	0	70.9	0	0	13.2
2015	7	8	13	44	8	35		0	0	0	0	0	0	70.92	0	0	13.2
2015	7	8	13	54	8	35		0	0	0	0	0	0	70.92	0	0	13.2
2015	7	8	14	4	8	35		0	0	0	0	0	0	70.9	0	0	13.2
2015	7	8	14	14	8	35		0	0	0	0	0	0	70.9	0	0	13.2
2015	7	8	14	24	8	34		0	0	0	0	0	0	70.99	0	0	13.2
2015	7	8	14	34	8	34		0	0	0	0	0	0	70.83	0	0	13.2
2015	7	8	14	44	8	34		0	0	0	0	0	0	70.74	0	0	13.2
2015	7	8	14	54	8	34		0	0	0	0	0	0	70.68	0	0	13.2
2015	7	8	15	4	8	34		0	0	0	0	0	0	70.66	0	0	13.4
2015	7	8	15	14	8	34		0	0	0	0	0	0	70.65	0	0	13.4
2015	7	8	15	24	8	34		0	0	0	0	0	0	70.68	0	0	13.4
2015	7	8	15	34	8	34		0	0	0	0	0	0	70.66	0	0	13.4
2015	7	8	15	44	8	34		0	0	0	0	0	0	70.7	0	0	13.4
2015	7	8	15	54	8	34		0	0	0	0	0	0	70.74	0	0	13.4
2015	7	8	16	4	8	35		0	0	0	0	0	0	70.84	0	0	13.4
2015	7	8	16	14	8	34		0	0	0	0	0	0	70.81	0	0	13.4
2015	7	8	16	24	8	34		0	0	0	0	0	0	70.81	0	0	13.4
2015	7	8	16	34	8	34		0	0	0	0	0	0	70.84	0	0	13.2
2015	7	8	16	44	8	34		0	0	0	0	0	0	70.81	0	0	13.2
2015	7	8	16	54	8	35		0	0	0	0	0	0	70.83	0	0	13.2
2015	7	8	17	4	8	34		0	0	0	0	0	0	70.81	0	0	13.2
2015	7	8	17	14	8	35		0	0	0	0	0	0	70.77	0	0	12.8
2015	7	8	17	24	8	35		0	0	0	0	0	0	70.79	0	0	13.2
2015	7	8	17	34	8	34		0	0	0	0	0	0	70.81	0	0	13.2
2015	7	8	17	44	8	34		0	0	0	0	0	0	70.79	0	0	12.6
2015	7	8	17	54	8	34		0	0	0	0	0	0	70.77	0	0	12.2
2015	7	8	18	4	8	34		0	0	0	0	0	0	70.77	0	0	12.2
2015	7	8	18	14	8	34		0	0	0	0	0	0	70.79	0	0	12.2
2015	7	8	18	24	8	34		0	0	0	0	0	0	70.79	0	0	12.2
2015	7	8	18	34	8	34		0	0	0	0	0	0	70.81	0	0	12.2
2015	7	8	18	44	8	34		0	0	0	0	0	0	70.83	0	0	12.2
2015	7	8	18	54	8	35		0	0	0	0	0	0	70.83	0	0	12.2
2015	7	8	19	4	8	34		0	0	0	0	0	0	70.84	0	0	12.2
2015	7	8	19	14	8	34		0	0	0	0	0	0	70.88	0	0	12.2
2015	7	8	19	24	8	35		0	0	0	0	0	0	70.86	0	0	12.2
2015	7	8	19	34	8	34		0	0	0	0	0	0	70.88	0	0	12.2
2015	7	8	19	44	8	35		0	0	0	0	0	0	70.9	0	0	12.2
2015	7	8	19	54	8	35		0	0	0	0	0	0	70.9	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	8	20	4	8	35	0	0	0	0	0	0	0	70.9	0	0	12.2
2015	7	8	20	14	8	35	0	0	0	0	0	0	0	70.9	0	0	12.2
2015	7	8	20	24	8	34	0	0	0	0	0	0	0	70.9	0	0	12.2
2015	7	8	20	34	8	34	0	0	0	0	0	0	0	70.9	0	0	12.2
2015	7	8	20	44	8	35	0	0	0	0	0	0	0	70.9	0	0	12.2
2015	7	8	20	54	8	34	0	0	0	0	0	0	0	70.92	0	0	12.2
2015	7	8	21	4	8	35	0	0	0	0	0	0	0	70.92	0	0	12.2
2015	7	8	21	14	8	34	0	0	0	0	0	0	0	70.92	0	0	12.2
2015	7	8	21	24	8	34	0	0	0	0	0	0	0	70.92	0	0	12.2
2015	7	8	21	34	8	34	0	0	0	0	0	0	0	70.92	0	0	12.2
2015	7	8	21	44	8	35	0	0	0	0	0	0	0	70.93	0	0	12.2
2015	7	8	21	54	8	34	0	0	0	0	0	0	0	70.92	0	0	12.2
2015	7	8	22	4	8	34	0	0	0	0	0	0	0	70.92	0	0	12.2
2015	7	8	22	14	8	34	0	0	0	0	0	0	0	70.93	0	0	12.2
2015	7	8	22	24	8	34	0	0	0	0	0	0	0	70.92	0	0	12.2
2015	7	8	22	34	8	35	0	0	0	0	0	0	0	70.92	0	0	12
2015	7	8	22	44	8	34	0	0	0	0	0	0	0	70.9	0	0	12.2
2015	7	8	22	54	8	34	0	0	0	0	0	0	0	70.9	0	0	12
2015	7	8	23	4	8	35	0	0	0	0	0	0	0	70.88	0	0	12
2015	7	8	23	14	8	34	0	0	0	0	0	0	0	70.84	0	0	12
2015	7	8	23	24	8	35	0	0	0	0	0	0	0	70.84	0	0	12
2015	7	8	23	34	8	35	0	0	0	0	0	0	0	70.83	0	0	12
2015	7	8	23	44	8	34	0	0	0	0	0	0	0	70.79	0	0	12
2015	7	8	23	54	8	35	0	0	0	0	0	0	0	70.79	0	0	12
2015	7	9	0	4	8	34	0	0	0	0	0	0	0	70.75	0	0	12
2015	7	9	0	14	8	35	0	0	0	0	0	0	0	70.74	0	0	12
2015	7	9	0	24	8	34	0	0	0	0	0	0	0	70.72	0	0	12
2015	7	9	0	34	8	35	0	0	0	0	0	0	0	70.68	0	0	12
2015	7	9	0	44	8	34	0	0	0	0	0	0	0	70.66	0	0	12
2015	7	9	0	54	8	35	0	0	0	0	0	0	0	70.63	0	0	12
2015	7	9	1	4	8	34	0	0	0	0	0	0	0	70.59	0	0	12
2015	7	9	1	14	8	35	0	0	0	0	0	0	0	70.56	0	0	12
2015	7	9	1	24	8	35	0	0	0	0	0	0	0	70.52	0	0	12
2015	7	9	1	34	8	35	0	0	0	0	0	0	0	70.48	0	0	12
2015	7	9	1	44	8	35	0	0	0	0	0	0	0	70.47	0	0	12
2015	7	9	1	54	8	34	0	0	0	0	0	0	0	70.43	0	0	12
2015	7	9	2	4	8	34	0	0	0	0	0	0	0	70.39	0	0	12
2015	7	9	2	14	8	35	0	0	0	0	0	0	0	70.36	0	0	12
2015	7	9	2	24	8	34	0	0	0	0	0	0	0	70.34	0	0	12
2015	7	9	2	34	8	35	0	0	0	0	0	0	0	70.3	0	0	12
2015	7	9	2	44	8	35	0	0	0	0	0	0	0	70.27	0	0	12
2015	7	9	2	54	8	34	0	0	0	0	0	0	0	70.23	0	0	12
2015	7	9	3	4	8	35	0	0	0	0	0	0	0	70.21	0	0	12
2015	7	9	3	14	8	34	0	0	0	0	0	0	0	70.16	0	0	12
2015	7	9	3	24	8	35	0	0	0	0	0	0	0	70.14	0	0	12
2015	7	9	3	34	8	34	0	0	0	0	0	0	0	70.11	0	0	12
2015	7	9	3	44	8	34	0	0	0	0	0	0	0	70.07	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	9	3	54	8	34	0	0	0	0	0	0	0	70.03	0	0	12
2015	7	9	4	4	8	34	0	0	0	0	0	0	0	70	0	0	12
2015	7	9	4	14	8	35	0	0	0	0	0	0	0	69.96	0	0	12
2015	7	9	4	24	8	35	0	0	0	0	0	0	0	69.94	0	0	12
2015	7	9	4	34	8	34	0	0	0	0	0	0	0	69.89	0	0	12
2015	7	9	4	44	8	34	0	0	0	0	0	0	0	69.87	0	0	12
2015	7	9	4	54	8	35	0	0	0	0	0	0	0	69.84	0	0	12
2015	7	9	5	4	8	35	0	0	0	0	0	0	0	69.8	0	0	12
2015	7	9	5	14	8	34	0	0	0	0	0	0	0	69.78	0	0	12
2015	7	9	5	24	8	34	0	0	0	0	0	0	0	69.75	0	0	12
2015	7	9	5	34	8	34	0	0	0	0	0	0	0	69.71	0	0	12
2015	7	9	5	44	8	35	0	0	0	0	0	0	0	69.69	0	0	12
2015	7	9	5	54	8	35	0	0	0	0	0	0	0	69.66	0	0	12
2015	7	9	6	4	8	35	0	0	0	0	0	0	0	69.62	0	0	12
2015	7	9	6	14	8	34	0	0	0	0	0	0	0	69.58	0	0	12
2015	7	9	6	24	8	34	0	0	0	0	0	0	0	69.57	0	0	12
2015	7	9	6	34	8	34	0	0	0	0	0	0	0	69.53	0	0	12
2015	7	9	6	44	8	35	0	0	0	0	0	0	0	69.49	0	0	12
2015	7	9	6	54	8	35	0	0	0	0	0	0	0	69.46	0	0	12.2
2015	7	9	7	4	8	35	0	0	0	0	0	0	0	69.44	0	0	12.2
2015	7	9	7	14	8	35	0	0	0	0	0	0	0	69.42	0	0	12.4
2015	7	9	7	24	8	35	0	0	0	0	0	0	0	69.42	0	0	12.4
2015	7	9	7	34	8	35	0	0	0	0	0	0	0	69.4	0	0	12.4
2015	7	9	7	44	8	35	0	0	0	0	0	0	0	69.37	0	0	12.6
2015	7	9	7	54	8	34	0	0	0	0	0	0	0	69.37	0	0	12.6
2015	7	9	8	4	8	35	0	0	0	0	0	0	0	69.37	0	0	12.6
2015	7	9	8	14	8	35	0	0	0	0	0	0	0	69.35	0	0	12.8
2015	7	9	8	24	8	34	0	0	0	0	0	0	0	69.37	0	0	12.8
2015	7	9	8	34	8	34	0	0	0	0	0	0	0	69.37	0	0	12.8
2015	7	9	8	44	8	35	0	0	0	0	0	0	0	69.39	0	0	12.8
2015	7	9	8	54	8	35	0	0	0	0	0	0	0	69.39	0	0	12.8
2015	7	9	9	4	8	35	0	0	0	0	0	0	0	69.4	0	0	13
2015	7	9	9	14	8	34	0	0	0	0	0	0	0	69.4	0	0	13
2015	7	9	9	24	8	35	0	0	0	0	0	0	0	69.42	0	0	13.4
2015	7	9	9	34	8	35	0	0	0	0	0	0	0	69.44	0	0	13.2
2015	7	9	9	44	8	35	0	0	0	0	0	0	0	69.44	0	0	13.4
2015	7	9	9	54	8	34	0	0	0	0	0	0	0	69.49	0	0	13.2
2015	7	9	10	4	8	35	0	0	0	0	0	0	0	69.46	0	0	13.2
2015	7	9	10	14	8	34	0	0	0	0	0	0	0	69.4	0	0	13.2
2015	7	9	10	24	8	35	0	0	0	0	0	0	0	69.31	0	0	13
2015	7	9	10	34	8	35	0	0	0	0	0	0	0	69.28	0	0	13
2015	7	9	10	44	8	35	0	0	0	0	0	0	0	69.28	0	0	13.4
2015	7	9	10	54	8	35	0	0	0	0	0	0	0	69.3	0	0	13.4
2015	7	9	11	4	8	35	0	0	0	0	0	0	0	69.33	0	0	13.4
2015	7	9	11	14	8	35	0	0	0	0	0	0	0	69.37	0	0	13.4
2015	7	9	11	24	8	35	0	0	0	0	0	0	0	69.24	0	0	13
2015	7	9	11	34	8	35	0	0	0	0	0	0	0	69.19	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	9	11	44	8	35	0	0	0	0	0	0	0	69.17	0	0	13.4
2015	7	9	11	54	8	35	0	0	0	0	0	0	0	69.15	0	0	13.6
2015	7	9	12	4	8	35	0	0	0	0	0	0	0	69.12	0	0	12.6
2015	7	9	12	14	8	35	0	0	0	0	0	0	0	69.06	0	0	12.4
2015	7	9	12	24	8	34	0	0	0	0	0	0	0	69.04	0	0	12.4
2015	7	9	12	34	8	35	0	0	0	0	0	0	0	69.03	0	0	12.4
2015	7	9	12	44	8	35	0	0	0	0	0	0	0	68.99	0	0	12.4
2015	7	9	12	54	8	35	0	0	0	0	0	0	0	69.01	0	0	12.4
2015	7	9	13	4	8	34	0	0	0	0	0	0	0	69.01	0	0	13.6
2015	7	9	13	14	8	35	0	0	0	0	0	0	0	69.04	0	0	13.6
2015	7	9	13	24	8	34	0	0	0	0	0	0	0	69.06	0	0	13.6
2015	7	9	13	34	8	35	0	0	0	0	0	0	0	69.03	0	0	13.4
2015	7	9	13	44	8	34	0	0	0	0	0	0	0	69.01	0	0	13.6
2015	7	9	13	54	8	34	0	0	0	0	0	0	0	68.99	0	0	13.6
2015	7	9	14	4	8	34	0	0	0	0	0	0	0	69.03	0	0	13.6
2015	7	9	14	14	8	35	0	0	0	0	0	0	0	69.13	0	0	13.6
2015	7	9	14	24	8	35	0	0	0	0	0	0	0	69.28	0	0	13.6
2015	7	9	14	34	8	35	0	0	0	0	0	0	0	69.33	0	0	13.6
2015	7	9	14	44	8	34	0	0	0	0	0	0	0	69.35	0	0	13.6
2015	7	9	14	54	8	35	0	0	0	0	0	0	0	69.37	0	0	13.6
2015	7	9	15	4	8	36	0	0	0	0	0	0	0	69.31	0	0	13.6
2015	7	9	15	14	8	35	0	0	0	0	0	0	0	69.39	0	0	13.4
2015	7	9	15	24	8	34	0	0	0	0	0	0	0	69.24	0	0	13.4
2015	7	9	15	34	8	35	0	0	0	0	0	0	0	69.19	0	0	13.4
2015	7	9	15	44	8	35	0	0	0	0	0	0	0	69.13	0	0	13.4
2015	7	9	15	54	8	35	0	0	0	0	0	0	0	69.1	0	0	13.4
2015	7	9	16	4	8	34	0	0	0	0	0	0	0	69.12	0	0	13.6
2015	7	9	16	14	8	34	0	0	0	0	0	0	0	69.24	0	0	13.6
2015	7	9	16	24	8	35	0	0	0	0	0	0	0	69.21	0	0	13.4
2015	7	9	16	34	8	35	0	0	0	0	0	0	0	69.08	0	0	13.4
2015	7	9	16	44	8	34	0	0	0	0	0	0	0	69.06	0	0	13.4
2015	7	9	16	54	8	35	0	0	0	0	0	0	0	69.04	0	0	13.6
2015	7	9	17	4	8	35	0	0	0	0	0	0	0	69.04	0	0	13.6
2015	7	9	17	14	8	35	0	0	0	0	0	0	0	69.04	0	0	13.6
2015	7	9	17	24	8	34	0	0	0	0	0	0	0	69.03	0	0	13
2015	7	9	17	34	8	34	0	0	0	0	0	0	0	69.03	0	0	13.4
2015	7	9	17	44	8	34	0	0	0	0	0	0	0	69.03	0	0	13.6
2015	7	9	17	54	8	35	0	0	0	0	0	0	0	69.03	0	0	13.2
2015	7	9	18	4	8	34	0	0	0	0	0	0	0	69.03	0	0	13.4
2015	7	9	18	14	8	34	0	0	0	0	0	0	0	69.04	0	0	13.4
2015	7	9	18	24	8	35	0	0	0	0	0	0	0	69.04	0	0	13.4
2015	7	9	18	34	8	34	0	0	0	0	0	0	0	69.04	0	0	12.8
2015	7	9	18	44	8	34	0	0	0	0	0	0	0	69.03	0	0	12.2
2015	7	9	18	54	8	34	0	0	0	0	0	0	0	69.01	0	0	12.2
2015	7	9	19	4	8	35	0	0	0	0	0	0	0	68.99	0	0	12.2
2015	7	9	19	14	8	35	0	0	0	0	0	0	0	68.97	0	0	12.2
2015	7	9	19	24	8	35	0	0	0	0	0	0	0	68.97	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	9	19	34	8	35		0	0	0	0	0	0	68.95	0	0	12.2
2015	7	9	19	44	8	35		0	0	0	0	0	0	68.94	0	0	12.2
2015	7	9	19	54	8	35		0	0	0	0	0	0	68.92	0	0	12.2
2015	7	9	20	4	8	34		0	0	0	0	0	0	68.9	0	0	12.2
2015	7	9	20	14	8	35		0	0	0	0	0	0	68.88	0	0	12.2
2015	7	9	20	24	8	34		0	0	0	0	0	0	68.88	0	0	12.2
2015	7	9	20	34	8	34		0	0	0	0	0	0	68.86	0	0	12.2
2015	7	9	20	44	8	34		0	0	0	0	0	0	68.85	0	0	12.2
2015	7	9	20	54	8	35		0	0	0	0	0	0	68.83	0	0	12.2
2015	7	9	21	4	8	34		0	0	0	0	0	0	68.81	0	0	12.2
2015	7	9	21	14	8	36		0	0	0	0	0	0	68.79	0	0	12.2
2015	7	9	21	24	8	34		0	0	0	0	0	0	68.77	0	0	12.2
2015	7	9	21	34	8	35		0	0	0	0	0	0	68.76	0	0	12.2
2015	7	9	21	44	8	34		0	0	0	0	0	0	68.76	0	0	12.2
2015	7	9	21	54	8	34		0	0	0	0	0	0	68.76	0	0	12.2
2015	7	9	22	4	8	35		0	0	0	0	0	0	68.74	0	0	12.2
2015	7	9	22	14	8	35		0	0	0	0	0	0	68.72	0	0	12.2
2015	7	9	22	24	8	35		0	0	0	0	0	0	68.7	0	0	12.2
2015	7	9	22	34	8	34		0	0	0	0	0	0	68.7	0	0	12
2015	7	9	22	44	8	35		0	0	0	0	0	0	68.68	0	0	12
2015	7	9	22	54	8	35		0	0	0	0	0	0	68.68	0	0	12
2015	7	9	23	4	8	35		0	0	0	0	0	0	68.67	0	0	12
2015	7	9	23	14	8	34		0	0	0	0	0	0	68.65	0	0	12
2015	7	9	23	24	8	34		0	0	0	0	0	0	68.63	0	0	12
2015	7	9	23	34	8	35		0	0	0	0	0	0	68.61	0	0	12
2015	7	9	23	44	8	35		0	0	0	0	0	0	68.59	0	0	12
2015	7	9	23	54	8	35		0	0	0	0	0	0	68.58	0	0	12
2015	7	10	0	4	8	35		0	0	0	0	0	0	68.54	0	0	12
2015	7	10	0	14	8	35		0	0	0	0	0	0	68.52	0	0	12
2015	7	10	0	24	8	35		0	0	0	0	0	0	68.5	0	0	12
2015	7	10	0	34	8	35		0	0	0	0	0	0	68.47	0	0	12
2015	7	10	0	44	8	35		0	0	0	0	0	0	68.43	0	0	12
2015	7	10	0	54	8	35		0	0	0	0	0	0	68.41	0	0	12
2015	7	10	1	4	8	34		0	0	0	0	0	0	68.38	0	0	12
2015	7	10	1	14	8	35		0	0	0	0	0	0	68.34	0	0	12
2015	7	10	1	24	8	35		0	0	0	0	0	0	68.32	0	0	12
2015	7	10	1	34	8	35		0	0	0	0	0	0	68.29	0	0	12
2015	7	10	1	44	8	35		0	0	0	0	0	0	68.25	0	0	12
2015	7	10	1	54	8	35		0	0	0	0	0	0	68.22	0	0	12
2015	7	10	2	4	8	35		0	0	0	0	0	0	68.18	0	0	12
2015	7	10	2	14	8	34		0	0	0	0	0	0	68.13	0	0	12
2015	7	10	2	24	8	34		0	0	0	0	0	0	68.09	0	0	12
2015	7	10	2	34	8	34		0	0	0	0	0	0	68.07	0	0	12
2015	7	10	2	44	8	35		0	0	0	0	0	0	68.04	0	0	12
2015	7	10	2	54	8	35		0	0	0	0	0	0	67.98	0	0	12
2015	7	10	3	4	8	34		0	0	0	0	0	0	67.95	0	0	12
2015	7	10	3	14	8	35		0	0	0	0	0	0	67.89	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	10	3	24	8	34	0	0	0	0	0	0	0	67.86	0	0	12
2015	7	10	3	34	8	35	0	0	0	0	0	0	0	67.8	0	0	12
2015	7	10	3	44	8	34	0	0	0	0	0	0	0	67.77	0	0	12
2015	7	10	3	54	8	35	0	0	0	0	0	0	0	67.73	0	0	12
2015	7	10	4	4	8	34	0	0	0	0	0	0	0	67.68	0	0	12
2015	7	10	4	14	8	35	0	0	0	0	0	0	0	67.64	0	0	12
2015	7	10	4	24	8	35	0	0	0	0	0	0	0	67.6	0	0	12
2015	7	10	4	34	8	35	0	0	0	0	0	0	0	67.55	0	0	12
2015	7	10	4	44	8	35	0	0	0	0	0	0	0	67.51	0	0	12
2015	7	10	4	54	8	35	0	0	0	0	0	0	0	67.46	0	0	12
2015	7	10	5	4	8	35	0	0	0	0	0	0	0	67.42	0	0	12
2015	7	10	5	14	8	35	0	0	0	0	0	0	0	67.37	0	0	12
2015	7	10	5	24	8	34	0	0	0	0	0	0	0	67.33	0	0	11.8
2015	7	10	5	34	8	35	0	0	0	0	0	0	0	67.28	0	0	11.8
2015	7	10	5	44	8	35	0	0	0	0	0	0	0	67.24	0	0	11.8
2015	7	10	5	54	8	35	0	0	0	0	0	0	0	67.21	0	0	11.8
2015	7	10	6	4	8	35	0	0	0	0	0	0	0	67.15	0	0	11.8
2015	7	10	6	14	8	35	0	0	0	0	0	0	0	67.12	0	0	11.8
2015	7	10	6	24	8	35	0	0	0	0	0	0	0	67.08	0	0	11.8
2015	7	10	6	34	8	35	0	0	0	0	0	0	0	67.03	0	0	11.8
2015	7	10	6	44	8	35	0	0	0	0	0	0	0	66.99	0	0	12
2015	7	10	6	54	8	35	0	0	0	0	0	0	0	66.96	0	0	12
2015	7	10	7	4	8	36	0	0	0	0	0	0	0	66.92	0	0	12.2
2015	7	10	7	14	8	35	0	0	0	0	0	0	0	66.9	0	0	12.2
2015	7	10	7	24	8	35	0	0	0	0	0	0	0	66.9	0	0	12.4
2015	7	10	7	34	8	35	0	0	0	0	0	0	0	66.9	0	0	12.4
2015	7	10	7	44	8	35	0	0	0	0	0	0	0	66.9	0	0	12.6
2015	7	10	7	54	8	35	0	0	0	0	0	0	0	66.88	0	0	12.8
2015	7	10	8	4	8	36	0	0	0	0	0	0	0	66.88	0	0	12.8
2015	7	10	8	14	8	35	0	0	0	0	0	0	0	66.88	0	0	12.8
2015	7	10	8	24	8	35	0	0	0	0	0	0	0	66.9	0	0	12.8
2015	7	10	8	34	8	35	0	0	0	0	0	0	0	66.88	0	0	12.8
2015	7	10	8	44	8	36	0	0	0	0	0	0	0	66.88	0	0	12.8
2015	7	10	8	54	8	35	0	0	0	0	0	0	0	66.92	0	0	13
2015	7	10	9	4	8	34	0	0	0	0	0	0	0	66.96	0	0	13
2015	7	10	9	14	8	35	0	0	0	0	0	0	0	66.99	0	0	13.2
2015	7	10	9	24	8	35	0	0	0	0	0	0	0	66.99	0	0	13.2
2015	7	10	9	34	8	35	0	0	0	0	0	0	0	67.01	0	0	13.2
2015	7	10	9	44	8	35	0	0	0	0	0	0	0	67.01	0	0	13.2
2015	7	10	9	54	8	35	0	0	0	0	0	0	0	67.05	0	0	13.2
2015	7	10	10	4	8	35	0	0	0	0	0	0	0	67.06	0	0	13.2
2015	7	10	10	14	8	35	0	0	0	0	0	0	0	67.08	0	0	13.2
2015	7	10	10	24	8	35	0	0	0	0	0	0	0	67.06	0	0	13.2
2015	7	10	10	34	8	35	0	0	0	0	0	0	0	67.12	0	0	13.2
2015	7	10	10	44	8	36	0	0	0	0	0	0	0	67.15	0	0	13.2
2015	7	10	10	54	8	34	0	0	0	0	0	0	0	67.19	0	0	13.2
2015	7	10	11	4	8	35	0	0	0	0	0	0	0	67.23	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	10	11	14	8	34	0	0	0	0	0	0	0	67.24	0	0	13.2
2015	7	10	11	24	8	35	0	0	0	0	0	0	0	67.28	0	0	13.2
2015	7	10	11	34	8	35	0	0	0	0	0	0	0	67.3	0	0	13.2
2015	7	10	11	44	8	35	0	0	0	0	0	0	0	67.32	0	0	13.2
2015	7	10	11	54	8	34	0	0	0	0	0	0	0	67.35	0	0	13.2
2015	7	10	12	4	8	35	0	0	0	0	0	0	0	67.39	0	0	13.2
2015	7	10	12	14	8	35	0	0	0	0	0	0	0	67.41	0	0	13.2
2015	7	10	12	24	8	35	0	0	0	0	0	0	0	67.44	0	0	13.2
2015	7	10	12	34	8	35	0	0	0	0	0	0	0	67.44	0	0	13.2
2015	7	10	12	44	8	35	0	0	0	0	0	0	0	67.48	0	0	13.2
2015	7	10	12	54	8	36	0	0	0	0	0	0	0	67.51	0	0	13.4
2015	7	10	13	4	8	35	0	0	0	0	0	0	0	67.55	0	0	13.4
2015	7	10	13	14	8	35	0	0	0	0	0	0	0	67.53	0	0	13.2
2015	7	10	13	24	8	36	0	0	0	0	0	0	0	67.44	0	0	13.2
2015	7	10	13	34	8	35	0	0	0	0	0	0	0	67.35	0	0	13.2
2015	7	10	13	44	8	35	0	0	0	0	0	0	0	67.41	0	0	13.2
2015	7	10	13	54	8	35	0	0	0	0	0	0	0	67.35	0	0	13.2
2015	7	10	14	4	8	34	0	0	0	0	0	0	0	67.28	0	0	13.2
2015	7	10	14	14	8	35	0	0	0	0	0	0	0	67.23	0	0	13.4
2015	7	10	14	24	8	35	0	0	0	0	0	0	0	67.23	0	0	13.4
2015	7	10	14	34	8	35	0	0	0	0	0	0	0	67.21	0	0	13.2
2015	7	10	14	44	8	35	0	0	0	0	0	0	0	67.19	0	0	13.4
2015	7	10	14	54	8	35	0	0	0	0	0	0	0	67.33	0	0	13.4
2015	7	10	15	4	8	35	0	0	0	0	0	0	0	67.23	0	0	13.4
2015	7	10	15	14	8	35	0	0	0	0	0	0	0	67.19	0	0	13.4
2015	7	10	15	24	8	35	0	0	0	0	0	0	0	67.19	0	0	13.4
2015	7	10	15	34	8	35	0	0	0	0	0	0	0	67.15	0	0	13
2015	7	10	15	44	8	35	0	0	0	0	0	0	0	67.12	0	0	12.4
2015	7	10	15	54	8	35	0	0	0	0	0	0	0	67.1	0	0	12.2
2015	7	10	16	4	8	35	0	0	0	0	0	0	0	67.08	0	0	12.2
2015	7	10	16	14	8	35	0	0	0	0	0	0	0	67.06	0	0	12.2
2015	7	10	16	24	8	35	0	0	0	0	0	0	0	67.06	0	0	12.2
2015	7	10	16	34	8	35	0	0	0	0	0	0	0	67.06	0	0	12.2
2015	7	10	16	44	8	35	0	0	0	0	0	0	0	67.06	0	0	12.2
2015	7	10	16	54	8	35	0	0	0	0	0	0	0	67.05	0	0	12.2
2015	7	10	17	4	8	35	0	0	0	0	0	0	0	67.06	0	0	12.2
2015	7	10	17	14	8	35	0	0	0	0	0	0	0	67.08	0	0	12.2
2015	7	10	17	24	8	34	0	0	0	0	0	0	0	67.1	0	0	12.2
2015	7	10	17	34	8	36	0	0	0	0	0	0	0	67.1	0	0	12.2
2015	7	10	17	44	8	35	0	0	0	0	0	0	0	67.1	0	0	12.2
2015	7	10	17	54	8	35	0	0	0	0	0	0	0	67.12	0	0	12.4
2015	7	10	18	4	8	35	0	0	0	0	0	0	0	67.14	0	0	12.2
2015	7	10	18	14	8	35	0	0	0	0	0	0	0	67.15	0	0	12.2
2015	7	10	18	24	8	36	0	0	0	0	0	0	0	67.17	0	0	12.4
2015	7	10	18	34	8	35	0	0	0	0	0	0	0	67.19	0	0	12.2
2015	7	10	18	44	8	35	0	0	0	0	0	0	0	67.21	0	0	12.2
2015	7	10	18	54	8	36	0	0	0	0	0	0	0	67.23	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	10	19	4	8	35	0	0	0	0	0	0	0	67.24	0	0	12.2
2015	7	10	19	14	8	35	0	0	0	0	0	0	0	67.24	0	0	12.2
2015	7	10	19	24	8	35	0	0	0	0	0	0	0	67.24	0	0	12.2
2015	7	10	19	34	8	35	0	0	0	0	0	0	0	67.26	0	0	12.2
2015	7	10	19	44	8	35	0	0	0	0	0	0	0	67.26	0	0	12.2
2015	7	10	19	54	8	36	0	0	0	0	0	0	0	67.28	0	0	12.2
2015	7	10	20	4	8	34	0	0	0	0	0	0	0	67.28	0	0	12.2
2015	7	10	20	14	8	35	0	0	0	0	0	0	0	67.3	0	0	12.2
2015	7	10	20	24	8	35	0	0	0	0	0	0	0	67.3	0	0	12.2
2015	7	10	20	34	8	35	0	0	0	0	0	0	0	67.32	0	0	12.2
2015	7	10	20	44	8	35	0	0	0	0	0	0	0	67.32	0	0	12.2
2015	7	10	20	54	8	34	0	0	0	0	0	0	0	67.32	0	0	12.2
2015	7	10	21	4	8	35	0	0	0	0	0	0	0	67.32	0	0	12.2
2015	7	10	21	14	8	34	0	0	0	0	0	0	0	67.32	0	0	12.2
2015	7	10	21	24	8	35	0	0	0	0	0	0	0	67.32	0	0	12.2
2015	7	10	21	34	8	34	0	0	0	0	0	0	0	67.32	0	0	12
2015	7	10	21	44	8	35	0	0	0	0	0	0	0	67.3	0	0	12.2
2015	7	10	21	54	8	35	0	0	0	0	0	0	0	67.28	0	0	12.2
2015	7	10	22	4	8	34	0	0	0	0	0	0	0	67.28	0	0	12.2
2015	7	10	22	14	8	35	0	0	0	0	0	0	0	67.26	0	0	12
2015	7	10	22	24	8	35	0	0	0	0	0	0	0	67.23	0	0	12
2015	7	10	22	34	8	35	0	0	0	0	0	0	0	67.23	0	0	12
2015	7	10	22	44	8	34	0	0	0	0	0	0	0	67.21	0	0	12
2015	7	10	22	54	8	35	0	0	0	0	0	0	0	67.19	0	0	12
2015	7	10	23	4	8	35	0	0	0	0	0	0	0	67.17	0	0	12
2015	7	10	23	14	8	36	0	0	0	0	0	0	0	67.14	0	0	12
2015	7	10	23	24	8	34	0	0	0	0	0	0	0	67.12	0	0	12
2015	7	10	23	34	8	35	0	0	0	0	0	0	0	67.1	0	0	12
2015	7	10	23	44	8	35	0	0	0	0	0	0	0	67.06	0	0	12
2015	7	10	23	54	8	35	0	0	0	0	0	0	0	67.05	0	0	12
2015	7	11	0	4	8	35	0	0	0	0	0	0	0	67.03	0	0	12
2015	7	11	0	14	8	35	0	0	0	0	0	0	0	66.97	0	0	12
2015	7	11	0	24	8	35	0	0	0	0	0	0	0	66.96	0	0	12
2015	7	11	0	34	8	35	0	0	0	0	0	0	0	66.94	0	0	12
2015	7	11	0	44	8	35	0	0	0	0	0	0	0	66.9	0	0	12
2015	7	11	0	54	8	35	0	0	0	0	0	0	0	66.87	0	0	12
2015	7	11	1	4	8	35	0	0	0	0	0	0	0	66.83	0	0	12
2015	7	11	1	14	8	35	0	0	0	0	0	0	0	66.79	0	0	12
2015	7	11	1	24	8	34	0	0	0	0	0	0	0	66.78	0	0	12
2015	7	11	1	34	8	35	0	0	0	0	0	0	0	66.74	0	0	12
2015	7	11	1	44	8	36	0	0	0	0	0	0	0	66.72	0	0	12
2015	7	11	1	54	8	36	0	0	0	0	0	0	0	66.69	0	0	12
2015	7	11	2	4	8	35	0	0	0	0	0	0	0	66.65	0	0	12
2015	7	11	2	14	8	35	0	0	0	0	0	0	0	66.63	0	0	12
2015	7	11	2	24	8	35	0	0	0	0	0	0	0	66.6	0	0	12
2015	7	11	2	34	8	35	0	0	0	0	0	0	0	66.58	0	0	12
2015	7	11	2	44	8	36	0	0	0	0	0	0	0	66.52	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	11	2	54	8	35		0	0	0	0	0	0	66.49	0	0	12
2015	7	11	3	4	8	35		0	0	0	0	0	0	66.45	0	0	12
2015	7	11	3	14	8	35		0	0	0	0	0	0	66.43	0	0	12
2015	7	11	3	24	8	35		0	0	0	0	0	0	66.38	0	0	12
2015	7	11	3	34	8	34		0	0	0	0	0	0	66.36	0	0	11.8
2015	7	11	3	44	8	35		0	0	0	0	0	0	66.31	0	0	12
2015	7	11	3	54	8	35		0	0	0	0	0	0	66.29	0	0	12
2015	7	11	4	4	8	35		0	0	0	0	0	0	66.24	0	0	12
2015	7	11	4	14	8	34		0	0	0	0	0	0	66.2	0	0	12
2015	7	11	4	24	8	35		0	0	0	0	0	0	66.16	0	0	12
2015	7	11	4	34	8	35		0	0	0	0	0	0	66.13	0	0	11.8
2015	7	11	4	44	8	35		0	0	0	0	0	0	66.07	0	0	11.8
2015	7	11	4	54	8	35		0	0	0	0	0	0	66.04	0	0	11.8
2015	7	11	5	4	8	35		0	0	0	0	0	0	66.02	0	0	11.8
2015	7	11	5	14	8	35		0	0	0	0	0	0	65.97	0	0	11.8
2015	7	11	5	24	8	35		0	0	0	0	0	0	65.93	0	0	11.8
2015	7	11	5	34	8	35		0	0	0	0	0	0	65.89	0	0	11.8
2015	7	11	5	44	8	35		0	0	0	0	0	0	65.86	0	0	11.8
2015	7	11	5	54	8	36		0	0	0	0	0	0	65.82	0	0	11.8
2015	7	11	6	4	8	35		0	0	0	0	0	0	65.79	0	0	11.8
2015	7	11	6	14	8	36		0	0	0	0	0	0	65.75	0	0	11.8
2015	7	11	6	24	8	35		0	0	0	0	0	0	65.71	0	0	11.8
2015	7	11	6	34	8	36		0	0	0	0	0	0	65.68	0	0	11.8
2015	7	11	6	44	8	35		0	0	0	0	0	0	65.64	0	0	12
2015	7	11	6	54	8	36		0	0	0	0	0	0	65.61	0	0	12
2015	7	11	7	4	8	35		0	0	0	0	0	0	65.59	0	0	12.2
2015	7	11	7	14	8	35		0	0	0	0	0	0	65.59	0	0	12.2
2015	7	11	7	24	8	36		0	0	0	0	0	0	65.57	0	0	12.4
2015	7	11	7	34	8	35		0	0	0	0	0	0	65.57	0	0	12.4
2015	7	11	7	44	8	35		0	0	0	0	0	0	65.57	0	0	12.6
2015	7	11	7	54	8	35		0	0	0	0	0	0	65.57	0	0	12.6
2015	7	11	8	4	8	35		0	0	0	0	0	0	65.57	0	0	12.8
2015	7	11	8	14	8	35		0	0	0	0	0	0	65.59	0	0	12.8
2015	7	11	8	24	8	35		0	0	0	0	0	0	65.59	0	0	12.8
2015	7	11	8	34	8	35		0	0	0	0	0	0	65.61	0	0	12.8
2015	7	11	8	44	8	35		0	0	0	0	0	0	65.62	0	0	13
2015	7	11	8	54	8	35		0	0	0	0	0	0	65.64	0	0	13
2015	7	11	9	4	8	36		0	0	0	0	0	0	65.66	0	0	13
2015	7	11	9	14	8	35		0	0	0	0	0	0	65.68	0	0	13.2
2015	7	11	9	24	8	35		0	0	0	0	0	0	65.71	0	0	13.2
2015	7	11	9	34	8	35		0	0	0	0	0	0	65.75	0	0	13.2
2015	7	11	9	44	8	35		0	0	0	0	0	0	65.77	0	0	13.2
2015	7	11	9	54	8	35		0	0	0	0	0	0	65.8	0	0	13.2
2015	7	11	10	4	8	35		0	0	0	0	0	0	65.84	0	0	13.2
2015	7	11	10	14	8	35		0	0	0	0	0	0	65.86	0	0	13.2
2015	7	11	10	24	8	35		0	0	0	0	0	0	65.84	0	0	13.2
2015	7	11	10	34	8	36		0	0	0	0	0	0	65.91	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	11	10	44	8	35	0	0	0	0	0	0	0	65.95	0	0	13.2
2015	7	11	10	54	8	36	0	0	0	0	0	0	0	65.98	0	0	13.2
2015	7	11	11	4	8	35	0	0	0	0	0	0	0	66	0	0	13.2
2015	7	11	11	14	8	35	0	0	0	0	0	0	0	66.04	0	0	13.2
2015	7	11	11	24	8	35	0	0	0	0	0	0	0	66.07	0	0	13.2
2015	7	11	11	34	8	35	0	0	0	0	0	0	0	66.09	0	0	13.2
2015	7	11	11	44	8	35	0	0	0	0	0	0	0	66.13	0	0	13.2
2015	7	11	11	54	8	35	0	0	0	0	0	0	0	66.16	0	0	13.2
2015	7	11	12	4	8	35	0	0	0	0	0	0	0	66.18	0	0	13.2
2015	7	11	12	14	8	35	0	0	0	0	0	0	0	66.22	0	0	13.2
2015	7	11	12	24	8	35	0	0	0	0	0	0	0	66.25	0	0	13.4
2015	7	11	12	34	8	35	0	0	0	0	0	0	0	66.27	0	0	13.4
2015	7	11	12	44	8	35	0	0	0	0	0	0	0	66.29	0	0	13.4
2015	7	11	12	54	8	35	0	0	0	0	0	0	0	66.31	0	0	13.4
2015	7	11	13	4	8	35	0	0	0	0	0	0	0	66.36	0	0	13.4
2015	7	11	13	14	8	35	0	0	0	0	0	0	0	66.4	0	0	13.4
2015	7	11	13	24	8	35	0	0	0	0	0	0	0	66.43	0	0	13.4
2015	7	11	13	34	8	35	0	0	0	0	0	0	0	66.47	0	0	13.2
2015	7	11	13	44	8	35	0	0	0	0	0	0	0	66.49	0	0	13.2
2015	7	11	13	54	8	34	0	0	0	0	0	0	0	66.49	0	0	13.2
2015	7	11	14	4	8	35	0	0	0	0	0	0	0	66.52	0	0	13.2
2015	7	11	14	14	8	35	0	0	0	0	0	0	0	66.52	0	0	13.2
2015	7	11	14	24	8	35	0	0	0	0	0	0	0	66.52	0	0	13.2
2015	7	11	14	34	8	35	0	0	0	0	0	0	0	66.54	0	0	13.2
2015	7	11	14	44	8	35	0	0	0	0	0	0	0	66.54	0	0	13.2
2015	7	11	14	54	8	35	0	0	0	0	0	0	0	66.45	0	0	13.2
2015	7	11	15	4	8	35	0	0	0	0	0	0	0	66.43	0	0	13.2
2015	7	11	15	14	8	35	0	0	0	0	0	0	0	66.43	0	0	13.2
2015	7	11	15	24	8	35	0	0	0	0	0	0	0	66.36	0	0	13.2
2015	7	11	15	34	8	35	0	0	0	0	0	0	0	66.34	0	0	13.2
2015	7	11	15	44	8	35	0	0	0	0	0	0	0	66.38	0	0	13.2
2015	7	11	15	54	8	35	0	0	0	0	0	0	0	66.47	0	0	13.2
2015	7	11	16	4	8	34	0	0	0	0	0	0	0	66.42	0	0	13.2
2015	7	11	16	14	8	36	0	0	0	0	0	0	0	66.31	0	0	13.2
2015	7	11	16	24	8	36	0	0	0	0	0	0	0	66.25	0	0	13.2
2015	7	11	16	34	8	36	0	0	0	0	0	0	0	66.29	0	0	13.2
2015	7	11	16	44	8	35	0	0	0	0	0	0	0	66.34	0	0	13.4
2015	7	11	16	54	8	35	0	0	0	0	0	0	0	66.36	0	0	13.4
2015	7	11	17	4	8	36	0	0	0	0	0	0	0	66.36	0	0	13.2
2015	7	11	17	14	8	35	0	0	0	0	0	0	0	66.34	0	0	13.2
2015	7	11	17	24	8	36	0	0	0	0	0	0	0	66.31	0	0	13.2
2015	7	11	17	34	8	35	0	0	0	0	0	0	0	66.33	0	0	13
2015	7	11	17	44	8	35	0	0	0	0	0	0	0	66.29	0	0	12.8
2015	7	11	17	54	8	35	0	0	0	0	0	0	0	66.31	0	0	13.2
2015	7	11	18	4	8	35	0	0	0	0	0	0	0	66.31	0	0	12.4
2015	7	11	18	14	8	35	0	0	0	0	0	0	0	66.31	0	0	12.2
2015	7	11	18	24	8	35	0	0	0	0	0	0	0	66.31	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	11	18	34	8	35		0	0	0	0	0	0	66.33	0	0	12.2
2015	7	11	18	44	8	35		0	0	0	0	0	0	66.34	0	0	12.2
2015	7	11	18	54	8	35		0	0	0	0	0	0	66.36	0	0	12.2
2015	7	11	19	4	8	35		0	0	0	0	0	0	66.38	0	0	12.2
2015	7	11	19	14	8	35		0	0	0	0	0	0	66.4	0	0	12.2
2015	7	11	19	24	8	35		0	0	0	0	0	0	66.42	0	0	12.2
2015	7	11	19	34	8	35		0	0	0	0	0	0	66.45	0	0	12.2
2015	7	11	19	44	8	35		0	0	0	0	0	0	66.47	0	0	12.2
2015	7	11	19	54	8	35		0	0	0	0	0	0	66.49	0	0	12.2
2015	7	11	20	4	8	34		0	0	0	0	0	0	66.52	0	0	12.2
2015	7	11	20	14	8	35		0	0	0	0	0	0	66.52	0	0	12.2
2015	7	11	20	24	8	35		0	0	0	0	0	0	66.56	0	0	12.2
2015	7	11	20	34	8	35		0	0	0	0	0	0	66.58	0	0	12.2
2015	7	11	20	44	8	34		0	0	0	0	0	0	66.6	0	0	12.2
2015	7	11	20	54	8	35		0	0	0	0	0	0	66.61	0	0	12.2
2015	7	11	21	4	8	35		0	0	0	0	0	0	66.63	0	0	12.2
2015	7	11	21	14	8	35		0	0	0	0	0	0	66.63	0	0	12.2
2015	7	11	21	24	8	35		0	0	0	0	0	0	66.65	0	0	12.2
2015	7	11	21	34	8	35		0	0	0	0	0	0	66.67	0	0	12.2
2015	7	11	21	44	8	35		0	0	0	0	0	0	66.69	0	0	12.2
2015	7	11	21	54	8	35		0	0	0	0	0	0	66.7	0	0	12.2
2015	7	11	22	4	8	35		0	0	0	0	0	0	66.72	0	0	12.2
2015	7	11	22	14	8	34		0	0	0	0	0	0	66.72	0	0	12.2
2015	7	11	22	24	8	35		0	0	0	0	0	0	66.74	0	0	12.2
2015	7	11	22	34	8	35		0	0	0	0	0	0	66.74	0	0	12
2015	7	11	22	44	8	35		0	0	0	0	0	0	66.74	0	0	12.2
2015	7	11	22	54	8	35		0	0	0	0	0	0	66.76	0	0	12.2
2015	7	11	23	4	8	35		0	0	0	0	0	0	66.76	0	0	12.2
2015	7	11	23	14	8	35		0	0	0	0	0	0	66.76	0	0	12
2015	7	11	23	24	8	35		0	0	0	0	0	0	66.76	0	0	12
2015	7	11	23	34	8	35		0	0	0	0	0	0	66.76	0	0	12
2015	7	11	23	44	8	35		0	0	0	0	0	0	66.74	0	0	12
2015	7	11	23	54	8	35		0	0	0	0	0	0	66.74	0	0	12
2015	7	12	0	4	8	35		0	0	0	0	0	0	66.72	0	0	12
2015	7	12	0	14	8	35		0	0	0	0	0	0	66.72	0	0	12
2015	7	12	0	24	8	35		0	0	0	0	0	0	66.7	0	0	12
2015	7	12	0	34	8	35		0	0	0	0	0	0	66.69	0	0	12
2015	7	12	0	44	8	35		0	0	0	0	0	0	66.69	0	0	12
2015	7	12	0	54	8	35		0	0	0	0	0	0	66.67	0	0	12
2015	7	12	1	4	8	34		0	0	0	0	0	0	66.65	0	0	12
2015	7	12	1	14	8	35		0	0	0	0	0	0	66.63	0	0	12
2015	7	12	1	24	8	35		0	0	0	0	0	0	66.61	0	0	12
2015	7	12	1	34	8	35		0	0	0	0	0	0	66.58	0	0	12
2015	7	12	1	44	8	35		0	0	0	0	0	0	66.58	0	0	12
2015	7	12	1	54	8	35		0	0	0	0	0	0	66.56	0	0	12
2015	7	12	2	4	8	35		0	0	0	0	0	0	66.52	0	0	12
2015	7	12	2	14	8	35		0	0	0	0	0	0	66.51	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	12	2	24	8	35		0	0	0	0	0	0	66.47	0	0	12
2015	7	12	2	34	8	35		0	0	0	0	0	0	66.45	0	0	12
2015	7	12	2	44	8	35		0	0	0	0	0	0	66.43	0	0	12
2015	7	12	2	54	8	35		0	0	0	0	0	0	66.4	0	0	12
2015	7	12	3	4	8	35		0	0	0	0	0	0	66.38	0	0	12
2015	7	12	3	14	8	35		0	0	0	0	0	0	66.34	0	0	12
2015	7	12	3	24	8	35		0	0	0	0	0	0	66.33	0	0	12
2015	7	12	3	34	8	35		0	0	0	0	0	0	66.29	0	0	12
2015	7	12	3	44	8	35		0	0	0	0	0	0	66.25	0	0	12
2015	7	12	3	54	8	35		0	0	0	0	0	0	66.22	0	0	12
2015	7	12	4	4	8	34		0	0	0	0	0	0	66.18	0	0	12
2015	7	12	4	14	8	35		0	0	0	0	0	0	66.16	0	0	12
2015	7	12	4	24	8	35		0	0	0	0	0	0	66.13	0	0	12
2015	7	12	4	34	8	35		0	0	0	0	0	0	66.09	0	0	12
2015	7	12	4	44	8	35		0	0	0	0	0	0	66.06	0	0	12
2015	7	12	4	54	8	35		0	0	0	0	0	0	66.04	0	0	12
2015	7	12	5	4	8	34		0	0	0	0	0	0	65.98	0	0	12
2015	7	12	5	14	8	36		0	0	0	0	0	0	65.95	0	0	12
2015	7	12	5	24	8	36		0	0	0	0	0	0	65.91	0	0	12
2015	7	12	5	34	8	35		0	0	0	0	0	0	65.88	0	0	12
2015	7	12	5	44	8	35		0	0	0	0	0	0	65.86	0	0	12
2015	7	12	5	54	8	35		0	0	0	0	0	0	65.82	0	0	12
2015	7	12	6	4	8	34		0	0	0	0	0	0	65.79	0	0	12
2015	7	12	6	14	8	35		0	0	0	0	0	0	65.75	0	0	12
2015	7	12	6	24	8	35		0	0	0	0	0	0	65.71	0	0	12
2015	7	12	6	34	8	35		0	0	0	0	0	0	65.7	0	0	12
2015	7	12	6	44	8	35		0	0	0	0	0	0	65.64	0	0	12
2015	7	12	6	54	8	35		0	0	0	0	0	0	65.62	0	0	12
2015	7	12	7	4	8	35		0	0	0	0	0	0	65.59	0	0	12.2
2015	7	12	7	14	8	35		0	0	0	0	0	0	65.59	0	0	12.2
2015	7	12	7	24	8	35		0	0	0	0	0	0	65.59	0	0	12.4
2015	7	12	7	34	8	35		0	0	0	0	0	0	65.59	0	0	12.4
2015	7	12	7	44	8	35		0	0	0	0	0	0	65.61	0	0	12.6
2015	7	12	7	54	8	35		0	0	0	0	0	0	65.62	0	0	12.6
2015	7	12	8	4	8	35		0	0	0	0	0	0	65.62	0	0	12.6
2015	7	12	8	14	8	35		0	0	0	0	0	0	65.64	0	0	12.8
2015	7	12	8	24	8	35		0	0	0	0	0	0	65.66	0	0	12.8
2015	7	12	8	34	8	35		0	0	0	0	0	0	65.68	0	0	12.8
2015	7	12	8	44	8	36		0	0	0	0	0	0	65.71	0	0	12.8
2015	7	12	8	54	8	35		0	0	0	0	0	0	65.73	0	0	12.8
2015	7	12	9	4	8	35		0	0	0	0	0	0	65.77	0	0	13
2015	7	12	9	14	8	35		0	0	0	0	0	0	65.79	0	0	13
2015	7	12	9	24	8	35		0	0	0	0	0	0	65.84	0	0	13.2
2015	7	12	9	34	8	35		0	0	0	0	0	0	65.86	0	0	13.2
2015	7	12	9	44	8	35		0	0	0	0	0	0	65.91	0	0	13.2
2015	7	12	9	54	8	35		0	0	0	0	0	0	65.93	0	0	13.2
2015	7	12	10	4	8	35		0	0	0	0	0	0	65.95	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	12	10	14	8	35		0	0	0	0	0	0	65.95	0	0	13.2
2015	7	12	10	24	8	35		0	0	0	0	0	0	66.02	0	0	13.2
2015	7	12	10	34	8	35		0	0	0	0	0	0	66.07	0	0	13.2
2015	7	12	10	44	8	35		0	0	0	0	0	0	66.15	0	0	13.2
2015	7	12	10	54	8	35		0	0	0	0	0	0	66.18	0	0	13.2
2015	7	12	11	4	8	35		0	0	0	0	0	0	66.24	0	0	13.2
2015	7	12	11	14	8	36		0	0	0	0	0	0	66.24	0	0	13.2
2015	7	12	11	24	8	35		0	0	0	0	0	0	66.27	0	0	13.2
2015	7	12	11	34	8	35		0	0	0	0	0	0	66.34	0	0	13.2
2015	7	12	11	44	8	35		0	0	0	0	0	0	66.38	0	0	13.2
2015	7	12	11	54	8	35		0	0	0	0	0	0	66.38	0	0	13.2
2015	7	12	12	4	8	34		0	0	0	0	0	0	66.42	0	0	13.2
2015	7	12	12	14	8	35		0	0	0	0	0	0	66.42	0	0	13.2
2015	7	12	12	24	8	35		0	0	0	0	0	0	66.49	0	0	13.2
2015	7	12	12	34	8	35		0	0	0	0	0	0	66.51	0	0	13.2
2015	7	12	12	44	8	35		0	0	0	0	0	0	66.56	0	0	13.2
2015	7	12	12	54	8	35		0	0	0	0	0	0	66.56	0	0	13.2
2015	7	12	13	4	8	35		0	0	0	0	0	0	66.61	0	0	13.2
2015	7	12	13	14	8	35		0	0	0	0	0	0	66.65	0	0	13.2
2015	7	12	13	24	8	35		0	0	0	0	0	0	66.63	0	0	13.2
2015	7	12	13	34	8	35		0	0	0	0	0	0	66.67	0	0	13.2
2015	7	12	13	44	8	35		0	0	0	0	0	0	66.7	0	0	13.2
2015	7	12	13	54	8	35		0	0	0	0	0	0	66.72	0	0	13.2
2015	7	12	14	4	8	35		0	0	0	0	0	0	66.74	0	0	13.2
2015	7	12	14	14	8	34		0	0	0	0	0	0	66.76	0	0	13.2
2015	7	12	14	24	8	35		0	0	0	0	0	0	66.72	0	0	13.2
2015	7	12	14	34	8	35		0	0	0	0	0	0	66.78	0	0	13.2
2015	7	12	14	44	8	36		0	0	0	0	0	0	66.76	0	0	13.2
2015	7	12	14	54	8	34		0	0	0	0	0	0	66.78	0	0	13.2
2015	7	12	15	4	8	35		0	0	0	0	0	0	66.7	0	0	13.2
2015	7	12	15	14	8	35		0	0	0	0	0	0	66.74	0	0	13.2
2015	7	12	15	24	8	36		0	0	0	0	0	0	66.76	0	0	13.2
2015	7	12	15	34	8	35		0	0	0	0	0	0	66.76	0	0	13.2
2015	7	12	15	44	8	35		0	0	0	0	0	0	66.74	0	0	13.2
2015	7	12	15	54	8	35		0	0	0	0	0	0	66.74	0	0	13.2
2015	7	12	16	4	8	34		0	0	0	0	0	0	66.74	0	0	13.2
2015	7	12	16	14	8	35		0	0	0	0	0	0	66.74	0	0	13.2
2015	7	12	16	24	8	35		0	0	0	0	0	0	66.74	0	0	13.2
2015	7	12	16	34	8	35		0	0	0	0	0	0	66.76	0	0	13.2
2015	7	12	16	44	8	34		0	0	0	0	0	0	66.76	0	0	13.2
2015	7	12	16	54	8	35		0	0	0	0	0	0	66.74	0	0	13.2
2015	7	12	17	4	8	35		0	0	0	0	0	0	66.74	0	0	13.2
2015	7	12	17	14	8	34		0	0	0	0	0	0	66.69	0	0	13.2
2015	7	12	17	24	8	35		0	0	0	0	0	0	66.69	0	0	13.2
2015	7	12	17	34	8	35		0	0	0	0	0	0	66.7	0	0	13
2015	7	12	17	44	8	35		0	0	0	0	0	0	66.69	0	0	13.2
2015	7	12	17	54	8	35		0	0	0	0	0	0	66.7	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	12	18	4	8	35	0	0	0	0	0	0	0	66.7	0	0	13.2
2015	7	12	18	14	8	35	0	0	0	0	0	0	0	66.72	0	0	13
2015	7	12	18	24	8	35	0	0	0	0	0	0	0	66.72	0	0	12.2
2015	7	12	18	34	8	35	0	0	0	0	0	0	0	66.74	0	0	12.2
2015	7	12	18	44	8	35	0	0	0	0	0	0	0	66.76	0	0	12.2
2015	7	12	18	54	8	35	0	0	0	0	0	0	0	66.78	0	0	12.2
2015	7	12	19	4	8	35	0	0	0	0	0	0	0	66.79	0	0	12.2
2015	7	12	19	14	8	35	0	0	0	0	0	0	0	66.81	0	0	12.2
2015	7	12	19	24	8	35	0	0	0	0	0	0	0	66.83	0	0	12.2
2015	7	12	19	34	8	35	0	0	0	0	0	0	0	66.87	0	0	12.2
2015	7	12	19	44	8	35	0	0	0	0	0	0	0	66.88	0	0	12.2
2015	7	12	19	54	8	35	0	0	0	0	0	0	0	66.9	0	0	12.2
2015	7	12	20	4	8	35	0	0	0	0	0	0	0	66.94	0	0	12.2
2015	7	12	20	14	8	35	0	0	0	0	0	0	0	66.97	0	0	12.2
2015	7	12	20	24	8	36	0	0	0	0	0	0	0	66.99	0	0	12.2
2015	7	12	20	34	8	34	0	0	0	0	0	0	0	67.01	0	0	12.2
2015	7	12	20	44	8	36	0	0	0	0	0	0	0	67.05	0	0	12.2
2015	7	12	20	54	8	35	0	0	0	0	0	0	0	67.08	0	0	12.2
2015	7	12	21	4	8	34	0	0	0	0	0	0	0	67.12	0	0	12.2
2015	7	12	21	14	8	35	0	0	0	0	0	0	0	67.14	0	0	12.2
2015	7	12	21	24	8	35	0	0	0	0	0	0	0	67.15	0	0	12.2
2015	7	12	21	34	8	35	0	0	0	0	0	0	0	67.19	0	0	12.2
2015	7	12	21	44	8	35	0	0	0	0	0	0	0	67.21	0	0	12.2
2015	7	12	21	54	8	35	0	0	0	0	0	0	0	67.24	0	0	12.2
2015	7	12	22	4	8	34	0	0	0	0	0	0	0	67.26	0	0	12.2
2015	7	12	22	14	8	35	0	0	0	0	0	0	0	67.28	0	0	12.2
2015	7	12	22	24	8	35	0	0	0	0	0	0	0	67.32	0	0	12.2
2015	7	12	22	34	8	35	0	0	0	0	0	0	0	67.33	0	0	12.2
2015	7	12	22	44	8	35	0	0	0	0	0	0	0	67.33	0	0	12.2
2015	7	12	22	54	8	35	0	0	0	0	0	0	0	67.35	0	0	12.2
2015	7	12	23	4	8	35	0	0	0	0	0	0	0	67.37	0	0	12.2
2015	7	12	23	14	8	35	0	0	0	0	0	0	0	67.37	0	0	12.2
2015	7	12	23	24	8	35	0	0	0	0	0	0	0	67.37	0	0	12
2015	7	12	23	34	8	35	0	0	0	0	0	0	0	67.39	0	0	12
2015	7	12	23	44	8	35	0	0	0	0	0	0	0	67.41	0	0	12
2015	7	12	23	54	8	35	0	0	0	0	0	0	0	67.41	0	0	12
2015	7	13	0	4	8	35	0	0	0	0	0	0	0	67.41	0	0	12
2015	7	13	0	14	8	35	0	0	0	0	0	0	0	67.41	0	0	12
2015	7	13	0	24	8	35	0	0	0	0	0	0	0	67.41	0	0	12
2015	7	13	0	34	8	35	0	0	0	0	0	0	0	67.41	0	0	12
2015	7	13	0	44	8	35	0	0	0	0	0	0	0	67.39	0	0	12
2015	7	13	0	54	8	35	0	0	0	0	0	0	0	67.39	0	0	12
2015	7	13	1	4	8	35	0	0	0	0	0	0	0	67.35	0	0	12
2015	7	13	1	14	8	35	0	0	0	0	0	0	0	67.35	0	0	12
2015	7	13	1	24	8	35	0	0	0	0	0	0	0	67.33	0	0	12
2015	7	13	1	34	8	34	0	0	0	0	0	0	0	67.32	0	0	12
2015	7	13	1	44	8	36	0	0	0	0	0	0	0	67.3	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	13	1	54	8	35		0	0	0	0	0	0	67.26	0	0	12
2015	7	13	2	4	8	35		0	0	0	0	0	0	67.23	0	0	12
2015	7	13	2	14	8	35		0	0	0	0	0	0	67.21	0	0	12
2015	7	13	2	24	8	35		0	0	0	0	0	0	67.17	0	0	12
2015	7	13	2	34	8	35		0	0	0	0	0	0	67.14	0	0	12
2015	7	13	2	44	8	35		0	0	0	0	0	0	67.12	0	0	12
2015	7	13	2	54	8	35		0	0	0	0	0	0	67.08	0	0	12
2015	7	13	3	4	8	36		0	0	0	0	0	0	67.05	0	0	12
2015	7	13	3	14	8	34		0	0	0	0	0	0	67.01	0	0	12
2015	7	13	3	24	8	35		0	0	0	0	0	0	66.97	0	0	12
2015	7	13	3	34	8	35		0	0	0	0	0	0	66.94	0	0	12
2015	7	13	3	44	8	35		0	0	0	0	0	0	66.9	0	0	12
2015	7	13	3	54	8	35		0	0	0	0	0	0	66.87	0	0	12
2015	7	13	4	4	8	34		0	0	0	0	0	0	66.83	0	0	12
2015	7	13	4	14	8	35		0	0	0	0	0	0	66.79	0	0	12
2015	7	13	4	24	8	35		0	0	0	0	0	0	66.76	0	0	12
2015	7	13	4	34	8	35		0	0	0	0	0	0	66.72	0	0	12
2015	7	13	4	44	8	35		0	0	0	0	0	0	66.69	0	0	12
2015	7	13	4	54	8	36		0	0	0	0	0	0	66.65	0	0	12
2015	7	13	5	4	8	35		0	0	0	0	0	0	66.61	0	0	12
2015	7	13	5	14	8	35		0	0	0	0	0	0	66.58	0	0	12
2015	7	13	5	24	8	35		0	0	0	0	0	0	66.56	0	0	12
2015	7	13	5	34	8	35		0	0	0	0	0	0	66.52	0	0	12
2015	7	13	5	44	8	35		0	0	0	0	0	0	66.49	0	0	12
2015	7	13	5	54	8	34		0	0	0	0	0	0	66.47	0	0	12
2015	7	13	6	4	8	35		0	0	0	0	0	0	66.45	0	0	12
2015	7	13	6	14	8	35		0	0	0	0	0	0	66.43	0	0	12
2015	7	13	6	24	8	35		0	0	0	0	0	0	66.42	0	0	12
2015	7	13	6	34	8	34		0	0	0	0	0	0	66.42	0	0	12
2015	7	13	6	44	8	34		0	0	0	0	0	0	66.42	0	0	12.2
2015	7	13	6	54	8	35		0	0	0	0	0	0	66.4	0	0	12.2
2015	7	13	7	4	8	34		0	0	0	0	0	0	66.42	0	0	12.4
2015	7	13	7	14	8	35		0	0	0	0	0	0	66.42	0	0	12.4
2015	7	13	7	24	8	34		0	0	0	0	0	0	66.43	0	0	12.4
2015	7	13	7	34	8	35		0	0	0	0	0	0	66.42	0	0	12.4
2015	7	13	7	44	8	35		0	0	0	0	0	0	66.47	0	0	12.6
2015	7	13	7	54	8	34		0	0	0	0	0	0	66.47	0	0	12.6
2015	7	13	8	4	8	35		0	0	0	0	0	0	66.47	0	0	12.6
2015	7	13	8	14	8	35		0	0	0	0	0	0	66.45	0	0	12.4
2015	7	13	8	24	8	35		0	0	0	0	0	0	66.47	0	0	12.6
2015	7	13	8	34	8	35		0	0	0	0	0	0	66.52	0	0	12.6
2015	7	13	8	44	8	35		0	0	0	0	0	0	66.54	0	0	12.8
2015	7	13	8	54	8	35		0	0	0	0	0	0	66.52	0	0	12.6
2015	7	13	9	4	8	35		0	0	0	0	0	0	66.61	0	0	12.8
2015	7	13	9	14	8	36		0	0	0	0	0	0	66.7	0	0	13
2015	7	13	9	24	8	35		0	0	0	0	0	0	66.74	0	0	13
2015	7	13	9	34	8	34		0	0	0	0	0	0	66.79	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	13	9	44	8	35	0	0	0	0	0	0	0	66.83	0	0	13.2
2015	7	13	9	54	8	35	0	0	0	0	0	0	0	66.88	0	0	13.2
2015	7	13	10	4	8	35	0	0	0	0	0	0	0	66.88	0	0	13.2
2015	7	13	10	14	8	35	0	0	0	0	0	0	0	66.92	0	0	13.2
2015	7	13	10	24	8	36	0	0	0	0	0	0	0	66.97	0	0	13.2
2015	7	13	10	34	8	35	0	0	0	0	0	0	0	67.03	0	0	13
2015	7	13	10	44	8	35	0	0	0	0	0	0	0	67.06	0	0	13.2
2015	7	13	10	54	8	34	0	0	0	0	0	0	0	67.14	0	0	13.2
2015	7	13	11	4	8	35	0	0	0	0	0	0	0	67.08	0	0	13.2
2015	7	13	11	14	8	35	0	0	0	0	0	0	0	67.08	0	0	13.2
2015	7	13	11	24	8	36	0	0	0	0	0	0	0	67.06	0	0	13.2
2015	7	13	11	34	8	35	0	0	0	0	0	0	0	67.14	0	0	13.2
2015	7	13	11	44	8	34	0	0	0	0	0	0	0	67.23	0	0	13.2
2015	7	13	11	54	8	35	0	0	0	0	0	0	0	67.28	0	0	13.2
2015	7	13	12	4	8	35	0	0	0	0	0	0	0	67.35	0	0	13.2
2015	7	13	12	14	8	35	0	0	0	0	0	0	0	67.39	0	0	13.2
2015	7	13	12	24	8	34	0	0	0	0	0	0	0	67.44	0	0	13.2
2015	7	13	12	34	8	35	0	0	0	0	0	0	0	67.46	0	0	13.2
2015	7	13	12	44	8	35	0	0	0	0	0	0	0	67.48	0	0	13.2
2015	7	13	12	54	8	35	0	0	0	0	0	0	0	67.5	0	0	13.2
2015	7	13	13	4	8	35	0	0	0	0	0	0	0	67.57	0	0	13.2
2015	7	13	13	14	8	35	0	0	0	0	0	0	0	67.59	0	0	13.2
2015	7	13	13	24	8	36	0	0	0	0	0	0	0	67.62	0	0	13.2
2015	7	13	13	34	8	35	0	0	0	0	0	0	0	67.66	0	0	13.2
2015	7	13	13	44	8	35	0	0	0	0	0	0	0	67.71	0	0	13.2
2015	7	13	13	54	8	35	0	0	0	0	0	0	0	67.71	0	0	13.2
2015	7	13	14	4	8	35	0	0	0	0	0	0	0	67.73	0	0	13.2
2015	7	13	14	14	8	35	0	0	0	0	0	0	0	67.75	0	0	13.2
2015	7	13	14	24	8	35	0	0	0	0	0	0	0	67.75	0	0	13.2
2015	7	13	14	34	8	34	0	0	0	0	0	0	0	67.78	0	0	13.2
2015	7	13	14	44	8	35	0	0	0	0	0	0	0	67.78	0	0	13.2
2015	7	13	14	54	8	35	0	0	0	0	0	0	0	67.78	0	0	13.2
2015	7	13	15	4	8	35	0	0	0	0	0	0	0	67.78	0	0	13.2
2015	7	13	15	14	8	35	0	0	0	0	0	0	0	67.78	0	0	13.2
2015	7	13	15	24	8	35	0	0	0	0	0	0	0	67.78	0	0	13.2
2015	7	13	15	34	8	35	0	0	0	0	0	0	0	67.78	0	0	13.2
2015	7	13	15	44	8	34	0	0	0	0	0	0	0	67.77	0	0	13.2
2015	7	13	15	54	8	35	0	0	0	0	0	0	0	67.71	0	0	13.2
2015	7	13	16	4	8	35	0	0	0	0	0	0	0	67.73	0	0	13.2
2015	7	13	16	14	8	35	0	0	0	0	0	0	0	67.73	0	0	13.2
2015	7	13	16	24	8	35	0	0	0	0	0	0	0	67.69	0	0	13.2
2015	7	13	16	34	8	34	0	0	0	0	0	0	0	67.69	0	0	13.2
2015	7	13	16	44	8	35	0	0	0	0	0	0	0	67.69	0	0	13.2
2015	7	13	16	54	8	35	0	0	0	0	0	0	0	67.69	0	0	13.2
2015	7	13	17	4	8	35	0	0	0	0	0	0	0	67.71	0	0	13.2
2015	7	13	17	14	8	35	0	0	0	0	0	0	0	67.64	0	0	13.2
2015	7	13	17	24	8	34	0	0	0	0	0	0	0	67.62	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	13	17	34	8	34	0	0	0	0	0	0	0	67.62	0	0	13
2015	7	13	17	44	8	35	0	0	0	0	0	0	0	67.64	0	0	13.2
2015	7	13	17	54	8	35	0	0	0	0	0	0	0	67.66	0	0	13.2
2015	7	13	18	4	8	35	0	0	0	0	0	0	0	67.68	0	0	13.2
2015	7	13	18	14	8	34	0	0	0	0	0	0	0	67.69	0	0	12.6
2015	7	13	18	24	8	35	0	0	0	0	0	0	0	67.71	0	0	13.2
2015	7	13	18	34	8	36	0	0	0	0	0	0	0	67.75	0	0	12.4
2015	7	13	18	44	8	35	0	0	0	0	0	0	0	67.77	0	0	12.2
2015	7	13	18	54	8	35	0	0	0	0	0	0	0	67.78	0	0	12.2
2015	7	13	19	4	8	35	0	0	0	0	0	0	0	67.8	0	0	12.2
2015	7	13	19	14	8	35	0	0	0	0	0	0	0	67.84	0	0	12.2
2015	7	13	19	24	8	34	0	0	0	0	0	0	0	67.84	0	0	12.2
2015	7	13	19	34	8	35	0	0	0	0	0	0	0	67.89	0	0	12.2
2015	7	13	19	44	8	35	0	0	0	0	0	0	0	67.91	0	0	12.2
2015	7	13	19	54	8	35	0	0	0	0	0	0	0	67.93	0	0	12.2
2015	7	13	20	4	8	35	0	0	0	0	0	0	0	67.96	0	0	12.2
2015	7	13	20	14	8	35	0	0	0	0	0	0	0	67.98	0	0	12.2
2015	7	13	20	24	8	35	0	0	0	0	0	0	0	68.02	0	0	12.2
2015	7	13	20	34	8	35	0	0	0	0	0	0	0	68.04	0	0	12.2
2015	7	13	20	44	8	35	0	0	0	0	0	0	0	68.05	0	0	12.2
2015	7	13	20	54	8	34	0	0	0	0	0	0	0	68.09	0	0	12.2
2015	7	13	21	4	8	35	0	0	0	0	0	0	0	68.11	0	0	12.2
2015	7	13	21	14	8	35	0	0	0	0	0	0	0	68.13	0	0	12.2
2015	7	13	21	24	8	35	0	0	0	0	0	0	0	68.14	0	0	12.2
2015	7	13	21	34	8	34	0	0	0	0	0	0	0	68.16	0	0	12.2
2015	7	13	21	44	8	35	0	0	0	0	0	0	0	68.18	0	0	12.2
2015	7	13	21	54	8	35	0	0	0	0	0	0	0	68.22	0	0	12.2
2015	7	13	22	4	8	34	0	0	0	0	0	0	0	68.23	0	0	12.2
2015	7	13	22	14	8	34	0	0	0	0	0	0	0	68.25	0	0	12.2
2015	7	13	22	24	8	35	0	0	0	0	0	0	0	68.27	0	0	12.2
2015	7	13	22	34	8	35	0	0	0	0	0	0	0	68.29	0	0	12.2
2015	7	13	22	44	8	35	0	0	0	0	0	0	0	68.29	0	0	12.2
2015	7	13	22	54	8	35	0	0	0	0	0	0	0	68.31	0	0	12.2
2015	7	13	23	4	8	34	0	0	0	0	0	0	0	68.31	0	0	12.2
2015	7	13	23	14	8	35	0	0	0	0	0	0	0	68.31	0	0	12.2
2015	7	13	23	24	8	34	0	0	0	0	0	0	0	68.32	0	0	12
2015	7	13	23	34	8	35	0	0	0	0	0	0	0	68.32	0	0	12
2015	7	13	23	44	8	34	0	0	0	0	0	0	0	68.32	0	0	12
2015	7	13	23	54	8	35	0	0	0	0	0	0	0	68.32	0	0	12
2015	7	14	0	4	8	35	0	0	0	0	0	0	0	68.32	0	0	12
2015	7	14	0	14	8	35	0	0	0	0	0	0	0	68.31	0	0	12
2015	7	14	0	24	8	35	0	0	0	0	0	0	0	68.31	0	0	12
2015	7	14	0	34	8	35	0	0	0	0	0	0	0	68.29	0	0	12
2015	7	14	0	44	8	35	0	0	0	0	0	0	0	68.27	0	0	12
2015	7	14	0	54	8	35	0	0	0	0	0	0	0	68.25	0	0	12
2015	7	14	1	4	8	35	0	0	0	0	0	0	0	68.25	0	0	12
2015	7	14	1	14	8	34	0	0	0	0	0	0	0	68.23	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	14	1	24	8	35		0	0	0	0	0	0	68.22	0	0	12
2015	7	14	1	34	8	35		0	0	0	0	0	0	68.18	0	0	12
2015	7	14	1	44	8	35		0	0	0	0	0	0	68.16	0	0	12
2015	7	14	1	54	8	34		0	0	0	0	0	0	68.14	0	0	12
2015	7	14	2	4	8	34		0	0	0	0	0	0	68.13	0	0	12
2015	7	14	2	14	8	34		0	0	0	0	0	0	68.09	0	0	12
2015	7	14	2	24	8	35		0	0	0	0	0	0	68.07	0	0	12
2015	7	14	2	34	8	35		0	0	0	0	0	0	68.04	0	0	12
2015	7	14	2	44	8	34		0	0	0	0	0	0	68.02	0	0	12
2015	7	14	2	54	8	35		0	0	0	0	0	0	67.98	0	0	12
2015	7	14	3	4	8	34		0	0	0	0	0	0	67.96	0	0	12
2015	7	14	3	14	8	35		0	0	0	0	0	0	67.93	0	0	12
2015	7	14	3	24	8	35		0	0	0	0	0	0	67.89	0	0	12
2015	7	14	3	34	8	35		0	0	0	0	0	0	67.86	0	0	12
2015	7	14	3	44	8	35		0	0	0	0	0	0	67.84	0	0	12
2015	7	14	3	54	8	35		0	0	0	0	0	0	67.8	0	0	12
2015	7	14	4	4	8	35		0	0	0	0	0	0	67.77	0	0	12
2015	7	14	4	14	8	35		0	0	0	0	0	0	67.73	0	0	12
2015	7	14	4	24	8	35		0	0	0	0	0	0	67.68	0	0	12
2015	7	14	4	34	8	35		0	0	0	0	0	0	67.68	0	0	12
2015	7	14	4	44	8	35		0	0	0	0	0	0	67.64	0	0	12
2015	7	14	4	54	8	35		0	0	0	0	0	0	67.6	0	0	12
2015	7	14	5	4	8	35		0	0	0	0	0	0	67.57	0	0	12
2015	7	14	5	14	8	35		0	0	0	0	0	0	67.53	0	0	12
2015	7	14	5	24	8	35		0	0	0	0	0	0	67.5	0	0	12
2015	7	14	5	34	8	35		0	0	0	0	0	0	67.46	0	0	12
2015	7	14	5	44	8	35		0	0	0	0	0	0	67.44	0	0	12
2015	7	14	5	54	8	34		0	0	0	0	0	0	67.41	0	0	12
2015	7	14	6	4	8	35		0	0	0	0	0	0	67.37	0	0	12
2015	7	14	6	14	8	35		0	0	0	0	0	0	67.33	0	0	12
2015	7	14	6	24	8	35		0	0	0	0	0	0	67.32	0	0	12
2015	7	14	6	34	8	35		0	0	0	0	0	0	67.28	0	0	12
2015	7	14	6	44	8	35		0	0	0	0	0	0	67.24	0	0	12
2015	7	14	6	54	8	35		0	0	0	0	0	0	67.23	0	0	12
2015	7	14	7	4	8	35		0	0	0	0	0	0	67.21	0	0	12.2
2015	7	14	7	14	8	35		0	0	0	0	0	0	67.21	0	0	12.2
2015	7	14	7	24	8	35		0	0	0	0	0	0	67.21	0	0	12.4
2015	7	14	7	34	8	35		0	0	0	0	0	0	67.21	0	0	12.4
2015	7	14	7	44	8	35		0	0	0	0	0	0	67.23	0	0	12.6
2015	7	14	7	54	8	35		0	0	0	0	0	0	67.23	0	0	12.6
2015	7	14	8	4	8	34		0	0	0	0	0	0	67.24	0	0	12.6
2015	7	14	8	14	8	34		0	0	0	0	0	0	67.26	0	0	12.8
2015	7	14	8	24	8	35		0	0	0	0	0	0	67.28	0	0	12.8
2015	7	14	8	34	8	34		0	0	0	0	0	0	67.32	0	0	12.8
2015	7	14	8	44	8	35		0	0	0	0	0	0	67.33	0	0	12.8
2015	7	14	8	54	8	35		0	0	0	0	0	0	67.37	0	0	12.8
2015	7	14	9	4	8	35		0	0	0	0	0	0	67.39	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	14	9	14	8	35		0	0	0	0	0	0	67.41	0	0	13
2015	7	14	9	24	8	35		0	0	0	0	0	0	67.44	0	0	13
2015	7	14	9	34	8	34		0	0	0	0	0	0	67.48	0	0	13
2015	7	14	9	44	8	35		0	0	0	0	0	0	67.51	0	0	13.2
2015	7	14	9	54	8	34		0	0	0	0	0	0	67.57	0	0	13.2
2015	7	14	10	4	8	35		0	0	0	0	0	0	67.59	0	0	13.2
2015	7	14	10	14	8	35		0	0	0	0	0	0	67.6	0	0	13.2
2015	7	14	10	24	8	35		0	0	0	0	0	0	67.66	0	0	13.2
2015	7	14	10	34	8	34		0	0	0	0	0	0	67.69	0	0	13.2
2015	7	14	10	44	8	35		0	0	0	0	0	0	67.75	0	0	13.2
2015	7	14	10	54	8	36		0	0	0	0	0	0	67.78	0	0	13.2
2015	7	14	11	4	8	35		0	0	0	0	0	0	67.82	0	0	13.2
2015	7	14	11	14	8	35		0	0	0	0	0	0	67.86	0	0	13.2
2015	7	14	11	24	8	35		0	0	0	0	0	0	67.91	0	0	13.2
2015	7	14	11	34	8	35		0	0	0	0	0	0	67.95	0	0	13.2
2015	7	14	11	44	8	34		0	0	0	0	0	0	67.98	0	0	13.2
2015	7	14	11	54	8	34		0	0	0	0	0	0	68.04	0	0	13.2
2015	7	14	12	4	8	35		0	0	0	0	0	0	68.05	0	0	13.2
2015	7	14	12	14	8	35		0	0	0	0	0	0	68.11	0	0	13.2
2015	7	14	12	24	8	35		0	0	0	0	0	0	68.13	0	0	13.2
2015	7	14	12	34	8	34		0	0	0	0	0	0	68.18	0	0	13.2
2015	7	14	12	44	8	35		0	0	0	0	0	0	68.18	0	0	13.2
2015	7	14	12	54	8	35		0	0	0	0	0	0	68.2	0	0	13.2
2015	7	14	13	4	8	35		0	0	0	0	0	0	68.23	0	0	13.2
2015	7	14	13	14	8	35		0	0	0	0	0	0	68.25	0	0	13.2
2015	7	14	13	24	8	35		0	0	0	0	0	0	68.31	0	0	13.2
2015	7	14	13	34	8	35		0	0	0	0	0	0	68.32	0	0	13.2
2015	7	14	13	44	8	35		0	0	0	0	0	0	68.32	0	0	13.2
2015	7	14	13	54	8	35		0	0	0	0	0	0	68.36	0	0	13.2
2015	7	14	14	4	8	35		0	0	0	0	0	0	68.36	0	0	13.2
2015	7	14	14	14	8	35		0	0	0	0	0	0	68.38	0	0	13.2
2015	7	14	14	24	8	35		0	0	0	0	0	0	68.36	0	0	13.2
2015	7	14	14	34	8	35		0	0	0	0	0	0	68.36	0	0	13.2
2015	7	14	14	44	8	35		0	0	0	0	0	0	68.4	0	0	13.2
2015	7	14	14	54	8	34		0	0	0	0	0	0	68.4	0	0	13.2
2015	7	14	15	4	8	35		0	0	0	0	0	0	68.4	0	0	13.2
2015	7	14	15	14	8	34		0	0	0	0	0	0	68.4	0	0	13.2
2015	7	14	15	24	8	34		0	0	0	0	0	0	68.4	0	0	13.2
2015	7	14	15	34	8	35		0	0	0	0	0	0	68.4	0	0	13.2
2015	7	14	15	44	8	35		0	0	0	0	0	0	68.4	0	0	13.2
2015	7	14	15	54	8	35		0	0	0	0	0	0	68.4	0	0	13.2
2015	7	14	16	4	8	35		0	0	0	0	0	0	68.4	0	0	13.2
2015	7	14	16	14	8	35		0	0	0	0	0	0	68.4	0	0	13.2
2015	7	14	16	24	8	34		0	0	0	0	0	0	68.38	0	0	13.2
2015	7	14	16	34	8	34		0	0	0	0	0	0	68.4	0	0	13.2
2015	7	14	16	44	8	35		0	0	0	0	0	0	68.4	0	0	13.2
2015	7	14	16	54	8	35		0	0	0	0	0	0	68.41	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	14	17	4	8	35		0	0	0	0	0	0	68.45	0	0	13.2
2015	7	14	17	14	8	35		0	0	0	0	0	0	68.43	0	0	13.2
2015	7	14	17	24	8	35		0	0	0	0	0	0	68.41	0	0	13.2
2015	7	14	17	34	8	34		0	0	0	0	0	0	68.43	0	0	13
2015	7	14	17	44	8	34		0	0	0	0	0	0	68.41	0	0	13.2
2015	7	14	17	54	8	34		0	0	0	0	0	0	68.41	0	0	13.2
2015	7	14	18	4	8	35		0	0	0	0	0	0	68.43	0	0	13.2
2015	7	14	18	14	8	35		0	0	0	0	0	0	68.45	0	0	13.2
2015	7	14	18	24	8	35		0	0	0	0	0	0	68.47	0	0	12.4
2015	7	14	18	34	8	35		0	0	0	0	0	0	68.49	0	0	12.2
2015	7	14	18	44	8	34		0	0	0	0	0	0	68.5	0	0	12.2
2015	7	14	18	54	8	35		0	0	0	0	0	0	68.54	0	0	12.2
2015	7	14	19	4	8	35		0	0	0	0	0	0	68.56	0	0	12.2
2015	7	14	19	14	8	35		0	0	0	0	0	0	68.58	0	0	12.2
2015	7	14	19	24	8	35		0	0	0	0	0	0	68.59	0	0	12.2
2015	7	14	19	34	8	35		0	0	0	0	0	0	68.63	0	0	12.2
2015	7	14	19	44	8	35		0	0	0	0	0	0	68.67	0	0	12.2
2015	7	14	19	54	8	34		0	0	0	0	0	0	68.68	0	0	12.2
2015	7	14	20	4	8	35		0	0	0	0	0	0	68.7	0	0	12.2
2015	7	14	20	14	8	35		0	0	0	0	0	0	68.72	0	0	12.2
2015	7	14	20	24	8	35		0	0	0	0	0	0	68.76	0	0	12.2
2015	7	14	20	34	8	35		0	0	0	0	0	0	68.79	0	0	12.2
2015	7	14	20	44	8	34		0	0	0	0	0	0	68.81	0	0	12.2
2015	7	14	20	54	8	34		0	0	0	0	0	0	68.83	0	0	12.2
2015	7	14	21	4	8	34		0	0	0	0	0	0	68.85	0	0	12.2
2015	7	14	21	14	8	35		0	0	0	0	0	0	68.86	0	0	12.2
2015	7	14	21	24	8	34		0	0	0	0	0	0	68.88	0	0	12.2
2015	7	14	21	34	8	34		0	0	0	0	0	0	68.9	0	0	12.2
2015	7	14	21	44	8	34		0	0	0	0	0	0	68.92	0	0	12.2
2015	7	14	21	54	8	35		0	0	0	0	0	0	68.95	0	0	12.2
2015	7	14	22	4	8	35		0	0	0	0	0	0	68.97	0	0	12.2
2015	7	14	22	14	8	34		0	0	0	0	0	0	68.99	0	0	12.2
2015	7	14	22	24	8	35		0	0	0	0	0	0	69.01	0	0	12.2
2015	7	14	22	34	8	34		0	0	0	0	0	0	69.03	0	0	12.2
2015	7	14	22	44	8	34		0	0	0	0	0	0	69.06	0	0	12.2
2015	7	14	22	54	8	35		0	0	0	0	0	0	69.08	0	0	12.2
2015	7	14	23	4	8	34		0	0	0	0	0	0	69.1	0	0	12.2
2015	7	14	23	14	8	35		0	0	0	0	0	0	69.1	0	0	12.2
2015	7	14	23	24	8	35		0	0	0	0	0	0	69.1	0	0	12.2
2015	7	14	23	34	8	34		0	0	0	0	0	0	69.12	0	0	12
2015	7	14	23	44	8	34		0	0	0	0	0	0	69.12	0	0	12
2015	7	14	23	54	8	34		0	0	0	0	0	0	69.12	0	0	12
2015	7	15	0	4	8	35		0	0	0	0	0	0	69.12	0	0	12
2015	7	15	0	14	8	35		0	0	0	0	0	0	69.1	0	0	12
2015	7	15	0	24	8	35		0	0	0	0	0	0	69.1	0	0	12
2015	7	15	0	34	8	35		0	0	0	0	0	0	69.08	0	0	12
2015	7	15	0	44	8	35		0	0	0	0	0	0	69.08	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	15	0	54	8	35		0	0	0	0	0	0	69.06	0	0	12
2015	7	15	1	4	8	35		0	0	0	0	0	0	69.04	0	0	12
2015	7	15	1	14	8	35		0	0	0	0	0	0	69.03	0	0	12
2015	7	15	1	24	8	34		0	0	0	0	0	0	69.01	0	0	12
2015	7	15	1	34	8	35		0	0	0	0	0	0	68.97	0	0	12
2015	7	15	1	44	8	35		0	0	0	0	0	0	68.95	0	0	12
2015	7	15	1	54	8	34		0	0	0	0	0	0	68.94	0	0	12
2015	7	15	2	4	8	35		0	0	0	0	0	0	68.9	0	0	12
2015	7	15	2	14	8	35		0	0	0	0	0	0	68.88	0	0	12
2015	7	15	2	24	8	35		0	0	0	0	0	0	68.85	0	0	12
2015	7	15	2	34	8	34		0	0	0	0	0	0	68.81	0	0	12
2015	7	15	2	44	8	35		0	0	0	0	0	0	68.77	0	0	12
2015	7	15	2	54	8	35		0	0	0	0	0	0	68.74	0	0	12
2015	7	15	3	4	8	35		0	0	0	0	0	0	68.7	0	0	12
2015	7	15	3	14	8	35		0	0	0	0	0	0	68.65	0	0	12
2015	7	15	3	24	8	35		0	0	0	0	0	0	68.61	0	0	12
2015	7	15	3	34	8	34		0	0	0	0	0	0	68.58	0	0	12
2015	7	15	3	44	8	35		0	0	0	0	0	0	68.54	0	0	12
2015	7	15	3	54	8	34		0	0	0	0	0	0	68.49	0	0	12
2015	7	15	4	4	8	35		0	0	0	0	0	0	68.45	0	0	12
2015	7	15	4	14	8	34		0	0	0	0	0	0	68.41	0	0	12
2015	7	15	4	24	8	35		0	0	0	0	0	0	68.38	0	0	12
2015	7	15	4	34	8	35		0	0	0	0	0	0	68.32	0	0	12
2015	7	15	4	44	8	35		0	0	0	0	0	0	68.29	0	0	12
2015	7	15	4	54	8	35		0	0	0	0	0	0	68.25	0	0	12
2015	7	15	5	4	8	35		0	0	0	0	0	0	68.2	0	0	12
2015	7	15	5	14	8	35		0	0	0	0	0	0	68.16	0	0	12
2015	7	15	5	24	8	35		0	0	0	0	0	0	68.13	0	0	12
2015	7	15	5	34	8	35		0	0	0	0	0	0	68.09	0	0	12
2015	7	15	5	44	8	34		0	0	0	0	0	0	68.04	0	0	12
2015	7	15	5	54	8	35		0	0	0	0	0	0	68	0	0	12
2015	7	15	6	4	8	34		0	0	0	0	0	0	67.96	0	0	12
2015	7	15	6	14	8	35		0	0	0	0	0	0	67.91	0	0	12
2015	7	15	6	24	8	34		0	0	0	0	0	0	67.87	0	0	12
2015	7	15	6	34	8	34		0	0	0	0	0	0	67.84	0	0	12
2015	7	15	6	44	8	34		0	0	0	0	0	0	67.8	0	0	12
2015	7	15	6	54	8	35		0	0	0	0	0	0	67.77	0	0	12
2015	7	15	7	4	8	35		0	0	0	0	0	0	67.75	0	0	12.2
2015	7	15	7	14	8	34		0	0	0	0	0	0	67.73	0	0	12.2
2015	7	15	7	24	8	35		0	0	0	0	0	0	67.75	0	0	12.4
2015	7	15	7	34	8	35		0	0	0	0	0	0	67.75	0	0	12.4
2015	7	15	7	44	8	35		0	0	0	0	0	0	67.75	0	0	12.6
2015	7	15	7	54	8	35		0	0	0	0	0	0	67.75	0	0	12.6
2015	7	15	8	4	8	35		0	0	0	0	0	0	67.75	0	0	12.6
2015	7	15	8	14	8	35		0	0	0	0	0	0	67.78	0	0	12.8
2015	7	15	8	24	8	35		0	0	0	0	0	0	67.78	0	0	12.8
2015	7	15	8	34	8	35		0	0	0	0	0	0	67.82	0	0	12.8

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	15	8	44	8	35	0	0	0	0	0	0	0	67.86	0	0	12.8
2015	7	15	8	54	8	35	0	0	0	0	0	0	0	67.87	0	0	12.8
2015	7	15	9	4	8	35	0	0	0	0	0	0	0	67.91	0	0	13
2015	7	15	9	14	8	35	0	0	0	0	0	0	0	67.95	0	0	13
2015	7	15	9	24	8	35	0	0	0	0	0	0	0	67.98	0	0	13.2
2015	7	15	9	34	8	34	0	0	0	0	0	0	0	68	0	0	13
2015	7	15	9	44	8	35	0	0	0	0	0	0	0	68.04	0	0	13
2015	7	15	9	54	8	35	0	0	0	0	0	0	0	68.07	0	0	13
2015	7	15	10	4	8	35	0	0	0	0	0	0	0	68.11	0	0	13
2015	7	15	10	14	8	35	0	0	0	0	0	0	0	68.13	0	0	13
2015	7	15	10	24	8	35	0	0	0	0	0	0	0	68.2	0	0	13
2015	7	15	10	34	8	34	0	0	0	0	0	0	0	68.23	0	0	13
2015	7	15	10	44	8	34	0	0	0	0	0	0	0	68.29	0	0	13
2015	7	15	10	54	8	34	0	0	0	0	0	0	0	68.32	0	0	13
2015	7	15	11	4	8	34	0	0	0	0	0	0	0	68.36	0	0	13
2015	7	15	11	14	8	35	0	0	0	0	0	0	0	68.4	0	0	13
2015	7	15	11	24	8	34	0	0	0	0	0	0	0	68.43	0	0	13
2015	7	15	11	34	8	36	0	0	0	0	0	0	0	68.47	0	0	13
2015	7	15	11	44	8	35	0	0	0	0	0	0	0	68.5	0	0	13
2015	7	15	11	54	8	35	0	0	0	0	0	0	0	68.56	0	0	13.2
2015	7	15	12	4	8	35	0	0	0	0	0	0	0	68.59	0	0	13.2
2015	7	15	12	14	8	34	0	0	0	0	0	0	0	68.63	0	0	13.2
2015	7	15	12	24	8	35	0	0	0	0	0	0	0	68.67	0	0	13.2
2015	7	15	12	34	8	34	0	0	0	0	0	0	0	68.7	0	0	13.2
2015	7	15	12	44	8	34	0	0	0	0	0	0	0	68.76	0	0	13.2
2015	7	15	12	54	8	35	0	0	0	0	0	0	0	68.77	0	0	13.2
2015	7	15	13	4	8	34	0	0	0	0	0	0	0	68.81	0	0	13.2
2015	7	15	13	14	8	34	0	0	0	0	0	0	0	68.83	0	0	13.2
2015	7	15	13	24	8	35	0	0	0	0	0	0	0	68.86	0	0	13.2
2015	7	15	13	34	8	35	0	0	0	0	0	0	0	68.88	0	0	13.2
2015	7	15	13	44	8	34	0	0	0	0	0	0	0	68.9	0	0	13.2
2015	7	15	13	54	8	34	0	0	0	0	0	0	0	68.92	0	0	13.2
2015	7	15	14	4	8	35	0	0	0	0	0	0	0	68.95	0	0	13.2
2015	7	15	14	14	8	35	0	0	0	0	0	0	0	68.95	0	0	13.2
2015	7	15	14	24	8	35	0	0	0	0	0	0	0	68.94	0	0	13.2
2015	7	15	14	34	8	34	0	0	0	0	0	0	0	68.97	0	0	13.2
2015	7	15	14	44	8	35	0	0	0	0	0	0	0	68.97	0	0	13.2
2015	7	15	14	54	8	35	0	0	0	0	0	0	0	68.95	0	0	13.2
2015	7	15	15	4	8	35	0	0	0	0	0	0	0	68.95	0	0	13.2
2015	7	15	15	14	8	34	0	0	0	0	0	0	0	68.94	0	0	13.2
2015	7	15	15	24	8	34	0	0	0	0	0	0	0	68.92	0	0	13.2
2015	7	15	15	34	8	35	0	0	0	0	0	0	0	68.92	0	0	13.2
2015	7	15	15	44	8	34	0	0	0	0	0	0	0	68.92	0	0	13.2
2015	7	15	15	54	8	35	0	0	0	0	0	0	0	68.92	0	0	13.2
2015	7	15	16	4	8	35	0	0	0	0	0	0	0	68.92	0	0	13.2
2015	7	15	16	14	8	35	0	0	0	0	0	0	0	68.9	0	0	13.2
2015	7	15	16	24	8	35	0	0	0	0	0	0	0	68.9	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	15	16	34	8	35		0	0	0	0	0	0	68.88	0	0	13.2
2015	7	15	16	44	8	35		0	0	0	0	0	0	68.88	0	0	13.2
2015	7	15	16	54	8	34		0	0	0	0	0	0	68.86	0	0	13.2
2015	7	15	17	4	8	35		0	0	0	0	0	0	68.85	0	0	13.2
2015	7	15	17	14	8	35		0	0	0	0	0	0	68.85	0	0	13.2
2015	7	15	17	24	8	35		0	0	0	0	0	0	68.83	0	0	13.2
2015	7	15	17	34	8	34		0	0	0	0	0	0	68.83	0	0	13
2015	7	15	17	44	8	36		0	0	0	0	0	0	68.83	0	0	13.2
2015	7	15	17	54	8	34		0	0	0	0	0	0	68.81	0	0	13.2
2015	7	15	18	4	8	35		0	0	0	0	0	0	68.81	0	0	13.2
2015	7	15	18	14	8	35		0	0	0	0	0	0	68.81	0	0	13.2
2015	7	15	18	24	8	35		0	0	0	0	0	0	68.83	0	0	12.8
2015	7	15	18	34	8	35		0	0	0	0	0	0	68.85	0	0	12.4
2015	7	15	18	44	8	35		0	0	0	0	0	0	68.86	0	0	12.2
2015	7	15	18	54	8	35		0	0	0	0	0	0	68.88	0	0	12.2
2015	7	15	19	4	8	35		0	0	0	0	0	0	68.88	0	0	12.2
2015	7	15	19	14	8	35		0	0	0	0	0	0	68.9	0	0	12.2
2015	7	15	19	24	8	34		0	0	0	0	0	0	68.92	0	0	12.2
2015	7	15	19	34	8	35		0	0	0	0	0	0	68.94	0	0	12.2
2015	7	15	19	44	8	35		0	0	0	0	0	0	68.95	0	0	12.2
2015	7	15	19	54	8	35		0	0	0	0	0	0	68.97	0	0	12.2
2015	7	15	20	4	8	34		0	0	0	0	0	0	68.99	0	0	12.2
2015	7	15	20	14	8	35		0	0	0	0	0	0	69.03	0	0	12.2
2015	7	15	20	24	8	35		0	0	0	0	0	0	69.04	0	0	12.2
2015	7	15	20	34	8	35		0	0	0	0	0	0	69.06	0	0	12.2
2015	7	15	20	44	8	34		0	0	0	0	0	0	69.08	0	0	12.2
2015	7	15	20	54	8	34		0	0	0	0	0	0	69.1	0	0	12.2
2015	7	15	21	4	8	35		0	0	0	0	0	0	69.13	0	0	12.2
2015	7	15	21	14	8	34		0	0	0	0	0	0	69.15	0	0	12.2
2015	7	15	21	24	8	35		0	0	0	0	0	0	69.17	0	0	12.2
2015	7	15	21	34	8	35		0	0	0	0	0	0	69.19	0	0	12.2
2015	7	15	21	44	8	35		0	0	0	0	0	0	69.21	0	0	12.2
2015	7	15	21	54	8	34		0	0	0	0	0	0	69.22	0	0	12.2
2015	7	15	22	4	8	34		0	0	0	0	0	0	69.24	0	0	12.2
2015	7	15	22	14	8	34		0	0	0	0	0	0	69.24	0	0	12.2
2015	7	15	22	24	8	35		0	0	0	0	0	0	69.26	0	0	12.2
2015	7	15	22	34	8	35		0	0	0	0	0	0	69.28	0	0	12
2015	7	15	22	44	8	35		0	0	0	0	0	0	69.3	0	0	12.2
2015	7	15	22	54	8	35		0	0	0	0	0	0	69.3	0	0	12.2
2015	7	15	23	4	8	35		0	0	0	0	0	0	69.31	0	0	12.2
2015	7	15	23	14	8	35		0	0	0	0	0	0	69.33	0	0	12.2
2015	7	15	23	24	8	34		0	0	0	0	0	0	69.33	0	0	12.2
2015	7	15	23	34	8	35		0	0	0	0	0	0	69.35	0	0	12
2015	7	15	23	44	8	35		0	0	0	0	0	0	69.35	0	0	12
2015	7	15	23	54	8	34		0	0	0	0	0	0	69.35	0	0	12
2015	7	16	0	4	8	35		0	0	0	0	0	0	69.35	0	0	12
2015	7	16	0	14	8	34		0	0	0	0	0	0	69.35	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	16	0	24	8	35		0	0	0	0	0	0	69.33	0	0	12
2015	7	16	0	34	8	35		0	0	0	0	0	0	69.33	0	0	12
2015	7	16	0	44	8	35		0	0	0	0	0	0	69.33	0	0	12
2015	7	16	0	54	8	34		0	0	0	0	0	0	69.31	0	0	12
2015	7	16	1	4	8	34		0	0	0	0	0	0	69.3	0	0	12
2015	7	16	1	14	8	34		0	0	0	0	0	0	69.3	0	0	12
2015	7	16	1	24	8	35		0	0	0	0	0	0	69.26	0	0	12
2015	7	16	1	34	8	34		0	0	0	0	0	0	69.26	0	0	12
2015	7	16	1	44	8	34		0	0	0	0	0	0	69.24	0	0	12
2015	7	16	1	54	8	35		0	0	0	0	0	0	69.21	0	0	12
2015	7	16	2	4	8	34		0	0	0	0	0	0	69.19	0	0	12
2015	7	16	2	14	8	35		0	0	0	0	0	0	69.17	0	0	12
2015	7	16	2	24	8	35		0	0	0	0	0	0	69.15	0	0	12
2015	7	16	2	34	8	34		0	0	0	0	0	0	69.12	0	0	12
2015	7	16	2	44	8	34		0	0	0	0	0	0	69.08	0	0	12
2015	7	16	2	54	8	34		0	0	0	0	0	0	69.06	0	0	12
2015	7	16	3	4	8	34		0	0	0	0	0	0	69.04	0	0	12
2015	7	16	3	14	8	35		0	0	0	0	0	0	69.01	0	0	12
2015	7	16	3	24	8	34		0	0	0	0	0	0	68.97	0	0	12
2015	7	16	3	34	8	35		0	0	0	0	0	0	68.95	0	0	12
2015	7	16	3	44	8	34		0	0	0	0	0	0	68.92	0	0	12
2015	7	16	3	54	8	34		0	0	0	0	0	0	68.9	0	0	12
2015	7	16	4	4	8	35		0	0	0	0	0	0	68.86	0	0	12
2015	7	16	4	14	8	35		0	0	0	0	0	0	68.83	0	0	12
2015	7	16	4	24	8	35		0	0	0	0	0	0	68.79	0	0	12
2015	7	16	4	34	8	35		0	0	0	0	0	0	68.77	0	0	12
2015	7	16	4	44	8	34		0	0	0	0	0	0	68.72	0	0	12
2015	7	16	4	54	8	34		0	0	0	0	0	0	68.7	0	0	12
2015	7	16	5	4	8	34		0	0	0	0	0	0	68.67	0	0	12
2015	7	16	5	14	8	35		0	0	0	0	0	0	68.63	0	0	12
2015	7	16	5	24	8	35		0	0	0	0	0	0	68.59	0	0	12
2015	7	16	5	34	8	35		0	0	0	0	0	0	68.52	0	0	12
2015	7	16	5	44	8	35		0	0	0	0	0	0	68.5	0	0	12
2015	7	16	5	54	8	35		0	0	0	0	0	0	68.45	0	0	12
2015	7	16	6	4	8	35		0	0	0	0	0	0	68.41	0	0	12
2015	7	16	6	14	8	35		0	0	0	0	0	0	68.4	0	0	12
2015	7	16	6	24	8	35		0	0	0	0	0	0	68.36	0	0	12
2015	7	16	6	34	8	35		0	0	0	0	0	0	68.32	0	0	12
2015	7	16	6	44	8	36		0	0	0	0	0	0	68.29	0	0	12
2015	7	16	6	54	8	34		0	0	0	0	0	0	68.25	0	0	12
2015	7	16	7	4	8	35		0	0	0	0	0	0	68.23	0	0	12.2
2015	7	16	7	14	8	35		0	0	0	0	0	0	68.2	0	0	12.2
2015	7	16	7	24	8	35		0	0	0	0	0	0	68.22	0	0	12.2
2015	7	16	7	34	8	34		0	0	0	0	0	0	68.22	0	0	12.4
2015	7	16	7	44	8	35		0	0	0	0	0	0	68.23	0	0	12.6
2015	7	16	7	54	8	35		0	0	0	0	0	0	68.23	0	0	12.6
2015	7	16	8	4	8	34		0	0	0	0	0	0	68.25	0	0	12.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	16	8	14	8	35		0	0	0	0	0	0	68.27	0	0	12.8
2015	7	16	8	24	8	35		0	0	0	0	0	0	68.29	0	0	12.8
2015	7	16	8	34	8	35		0	0	0	0	0	0	68.31	0	0	12.8
2015	7	16	8	44	8	34		0	0	0	0	0	0	68.32	0	0	12.8
2015	7	16	8	54	8	35		0	0	0	0	0	0	68.34	0	0	12.8
2015	7	16	9	4	8	34		0	0	0	0	0	0	68.38	0	0	13
2015	7	16	9	14	8	35		0	0	0	0	0	0	68.4	0	0	13
2015	7	16	9	24	8	35		0	0	0	0	0	0	68.41	0	0	13
2015	7	16	9	34	8	35		0	0	0	0	0	0	68.45	0	0	13
2015	7	16	9	44	8	35		0	0	0	0	0	0	68.49	0	0	13
2015	7	16	9	54	8	34		0	0	0	0	0	0	68.52	0	0	13
2015	7	16	10	4	8	34		0	0	0	0	0	0	68.54	0	0	13
2015	7	16	10	14	8	34		0	0	0	0	0	0	68.59	0	0	13
2015	7	16	10	24	8	35		0	0	0	0	0	0	68.61	0	0	13
2015	7	16	10	34	8	35		0	0	0	0	0	0	68.67	0	0	13
2015	7	16	10	44	8	35		0	0	0	0	0	0	68.72	0	0	13
2015	7	16	10	54	8	34		0	0	0	0	0	0	68.74	0	0	13.2
2015	7	16	11	4	8	35		0	0	0	0	0	0	68.77	0	0	13.2
2015	7	16	11	14	8	34		0	0	0	0	0	0	68.79	0	0	13.2
2015	7	16	11	24	8	35		0	0	0	0	0	0	68.83	0	0	13.2
2015	7	16	11	34	8	34		0	0	0	0	0	0	68.85	0	0	13.2
2015	7	16	11	44	8	35		0	0	0	0	0	0	68.88	0	0	13.2
2015	7	16	11	54	8	34		0	0	0	0	0	0	68.95	0	0	13.2
2015	7	16	12	4	8	35		0	0	0	0	0	0	68.99	0	0	13.2
2015	7	16	12	14	8	35		0	0	0	0	0	0	69.01	0	0	13.2
2015	7	16	12	24	8	35		0	0	0	0	0	0	69.04	0	0	13.2
2015	7	16	12	34	8	35		0	0	0	0	0	0	69.1	0	0	13.2
2015	7	16	12	44	8	35		0	0	0	0	0	0	69.1	0	0	13.2
2015	7	16	12	54	8	35		0	0	0	0	0	0	69.13	0	0	13.2
2015	7	16	13	4	8	34		0	0	0	0	0	0	69.17	0	0	13.2
2015	7	16	13	14	8	34		0	0	0	0	0	0	69.19	0	0	13.2
2015	7	16	13	24	8	35		0	0	0	0	0	0	69.21	0	0	13.2
2015	7	16	13	34	8	35		0	0	0	0	0	0	69.26	0	0	13.2
2015	7	16	13	44	8	35		0	0	0	0	0	0	69.3	0	0	13.2
2015	7	16	13	54	8	35		0	0	0	0	0	0	69.28	0	0	13.2
2015	7	16	14	4	8	34		0	0	0	0	0	0	69.3	0	0	13.2
2015	7	16	14	14	8	35		0	0	0	0	0	0	69.28	0	0	13.2
2015	7	16	14	24	8	35		0	0	0	0	0	0	69.28	0	0	13.2
2015	7	16	14	34	8	35		0	0	0	0	0	0	69.3	0	0	13.2
2015	7	16	14	44	8	34		0	0	0	0	0	0	69.33	0	0	13.2
2015	7	16	14	54	8	35		0	0	0	0	0	0	69.33	0	0	13.2
2015	7	16	15	4	8	34		0	0	0	0	0	0	69.35	0	0	13.2
2015	7	16	15	14	8	34		0	0	0	0	0	0	69.33	0	0	13.2
2015	7	16	15	24	8	34		0	0	0	0	0	0	69.31	0	0	13.2
2015	7	16	15	34	8	35		0	0	0	0	0	0	69.31	0	0	13.2
2015	7	16	15	44	8	35		0	0	0	0	0	0	69.3	0	0	13.2
2015	7	16	15	54	8	34		0	0	0	0	0	0	69.22	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	16	16	4	8	34	0	0	0	0	0	0	0	69.17	0	0	13.2
2015	7	16	16	14	8	34	0	0	0	0	0	0	0	69.13	0	0	13.2
2015	7	16	16	24	8	34	0	0	0	0	0	0	0	69.13	0	0	13.2
2015	7	16	16	34	8	34	0	0	0	0	0	0	0	69.19	0	0	13.2
2015	7	16	16	44	8	34	0	0	0	0	0	0	0	69.19	0	0	13.2
2015	7	16	16	54	8	35	0	0	0	0	0	0	0	69.15	0	0	12.6
2015	7	16	17	4	8	35	0	0	0	0	0	0	0	69.17	0	0	13.2
2015	7	16	17	14	8	34	0	0	0	0	0	0	0	69.19	0	0	13
2015	7	16	17	24	8	35	0	0	0	0	0	0	0	69.19	0	0	13.2
2015	7	16	17	34	8	35	0	0	0	0	0	0	0	69.19	0	0	13.2
2015	7	16	17	44	8	34	0	0	0	0	0	0	0	69.17	0	0	13.2
2015	7	16	17	54	8	35	0	0	0	0	0	0	0	69.17	0	0	12.4
2015	7	16	18	4	8	35	0	0	0	0	0	0	0	69.17	0	0	12.4
2015	7	16	18	14	8	35	0	0	0	0	0	0	0	69.17	0	0	12.2
2015	7	16	18	24	8	35	0	0	0	0	0	0	0	69.19	0	0	12.2
2015	7	16	18	34	8	34	0	0	0	0	0	0	0	69.21	0	0	12.2
2015	7	16	18	44	8	35	0	0	0	0	0	0	0	69.21	0	0	12.2
2015	7	16	18	54	8	35	0	0	0	0	0	0	0	69.24	0	0	12.2
2015	7	16	19	4	8	34	0	0	0	0	0	0	0	69.26	0	0	12.2
2015	7	16	19	14	8	35	0	0	0	0	0	0	0	69.26	0	0	12.2
2015	7	16	19	24	8	35	0	0	0	0	0	0	0	69.3	0	0	12.2
2015	7	16	19	34	8	34	0	0	0	0	0	0	0	69.31	0	0	12.2
2015	7	16	19	44	8	34	0	0	0	0	0	0	0	69.33	0	0	12.2
2015	7	16	19	54	8	34	0	0	0	0	0	0	0	69.35	0	0	12.2
2015	7	16	20	4	8	35	0	0	0	0	0	0	0	69.37	0	0	12.2
2015	7	16	20	14	8	34	0	0	0	0	0	0	0	69.39	0	0	12.2
2015	7	16	20	24	8	35	0	0	0	0	0	0	0	69.4	0	0	12.2
2015	7	16	20	34	8	35	0	0	0	0	0	0	0	69.42	0	0	12.2
2015	7	16	20	44	8	34	0	0	0	0	0	0	0	69.46	0	0	12.2
2015	7	16	20	54	8	35	0	0	0	0	0	0	0	69.46	0	0	12.2
2015	7	16	21	4	8	34	0	0	0	0	0	0	0	69.48	0	0	12.2
2015	7	16	21	14	8	34	0	0	0	0	0	0	0	69.51	0	0	12.2
2015	7	16	21	24	8	35	0	0	0	0	0	0	0	69.53	0	0	12.2
2015	7	16	21	34	8	35	0	0	0	0	0	0	0	69.53	0	0	12.2
2015	7	16	21	44	8	35	0	0	0	0	0	0	0	69.55	0	0	12.2
2015	7	16	21	54	8	34	0	0	0	0	0	0	0	69.55	0	0	12.2
2015	7	16	22	4	8	35	0	0	0	0	0	0	0	69.58	0	0	12.2
2015	7	16	22	14	8	35	0	0	0	0	0	0	0	69.58	0	0	12.2
2015	7	16	22	24	8	35	0	0	0	0	0	0	0	69.6	0	0	12.2
2015	7	16	22	34	8	35	0	0	0	0	0	0	0	69.62	0	0	12.2
2015	7	16	22	44	8	34	0	0	0	0	0	0	0	69.64	0	0	12.2
2015	7	16	22	54	8	35	0	0	0	0	0	0	0	69.64	0	0	12.2
2015	7	16	23	4	8	35	0	0	0	0	0	0	0	69.66	0	0	12.2
2015	7	16	23	14	8	35	0	0	0	0	0	0	0	69.66	0	0	12.2
2015	7	16	23	24	8	35	0	0	0	0	0	0	0	69.66	0	0	12
2015	7	16	23	34	8	34	0	0	0	0	0	0	0	69.64	0	0	12
2015	7	16	23	44	8	34	0	0	0	0	0	0	0	69.64	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	16	23	54	8	35		0	0	0	0	0	0	69.64	0	0	12
2015	7	17	0	4	8	35		0	0	0	0	0	0	69.62	0	0	12
2015	7	17	0	14	8	34		0	0	0	0	0	0	69.62	0	0	12
2015	7	17	0	24	8	34		0	0	0	0	0	0	69.6	0	0	12
2015	7	17	0	34	8	34		0	0	0	0	0	0	69.58	0	0	12
2015	7	17	0	44	8	35		0	0	0	0	0	0	69.57	0	0	12
2015	7	17	0	54	8	34		0	0	0	0	0	0	69.55	0	0	12
2015	7	17	1	4	8	35		0	0	0	0	0	0	69.53	0	0	12
2015	7	17	1	14	8	34		0	0	0	0	0	0	69.51	0	0	12
2015	7	17	1	24	8	35		0	0	0	0	0	0	69.48	0	0	12
2015	7	17	1	34	8	34		0	0	0	0	0	0	69.46	0	0	12
2015	7	17	1	44	8	35		0	0	0	0	0	0	69.42	0	0	12
2015	7	17	1	54	8	34		0	0	0	0	0	0	69.39	0	0	12
2015	7	17	2	4	8	34		0	0	0	0	0	0	69.37	0	0	12
2015	7	17	2	14	8	34		0	0	0	0	0	0	69.33	0	0	12
2015	7	17	2	24	8	35		0	0	0	0	0	0	69.3	0	0	12
2015	7	17	2	34	8	35		0	0	0	0	0	0	69.26	0	0	12
2015	7	17	2	44	8	35		0	0	0	0	0	0	69.24	0	0	12
2015	7	17	2	54	8	35		0	0	0	0	0	0	69.21	0	0	12
2015	7	17	3	4	8	35		0	0	0	0	0	0	69.17	0	0	12
2015	7	17	3	14	8	34		0	0	0	0	0	0	69.13	0	0	12
2015	7	17	3	24	8	34		0	0	0	0	0	0	69.1	0	0	12
2015	7	17	3	34	8	34		0	0	0	0	0	0	69.06	0	0	12
2015	7	17	3	44	8	34		0	0	0	0	0	0	69.03	0	0	12
2015	7	17	3	54	8	35		0	0	0	0	0	0	68.99	0	0	12
2015	7	17	4	4	8	35		0	0	0	0	0	0	68.95	0	0	12
2015	7	17	4	14	8	35		0	0	0	0	0	0	68.92	0	0	12
2015	7	17	4	24	8	35		0	0	0	0	0	0	68.88	0	0	12
2015	7	17	4	34	8	34		0	0	0	0	0	0	68.85	0	0	12
2015	7	17	4	44	8	35		0	0	0	0	0	0	68.79	0	0	12
2015	7	17	4	54	8	35		0	0	0	0	0	0	68.76	0	0	12
2015	7	17	5	4	8	35		0	0	0	0	0	0	68.7	0	0	12
2015	7	17	5	14	8	35		0	0	0	0	0	0	68.68	0	0	12
2015	7	17	5	24	8	35		0	0	0	0	0	0	68.63	0	0	12
2015	7	17	5	34	8	35		0	0	0	0	0	0	68.58	0	0	11.8
2015	7	17	5	44	8	34		0	0	0	0	0	0	68.54	0	0	12
2015	7	17	5	54	8	34		0	0	0	0	0	0	68.49	0	0	12
2015	7	17	6	4	8	35		0	0	0	0	0	0	68.43	0	0	12
2015	7	17	6	14	8	34		0	0	0	0	0	0	68.41	0	0	12
2015	7	17	6	24	8	35		0	0	0	0	0	0	68.36	0	0	12
2015	7	17	6	34	8	34		0	0	0	0	0	0	68.32	0	0	12
2015	7	17	6	44	8	34		0	0	0	0	0	0	68.29	0	0	12
2015	7	17	6	54	8	35		0	0	0	0	0	0	68.25	0	0	12
2015	7	17	7	4	8	35		0	0	0	0	0	0	68.22	0	0	12.2
2015	7	17	7	14	8	34		0	0	0	0	0	0	68.18	0	0	12.2
2015	7	17	7	24	8	35		0	0	0	0	0	0	68.2	0	0	12.4
2015	7	17	7	34	8	35		0	0	0	0	0	0	68.18	0	0	12.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	17	7	44	8	35		0	0	0	0	0	0	68.18	0	0	12.6
2015	7	17	7	54	8	34		0	0	0	0	0	0	68.18	0	0	12.6
2015	7	17	8	4	8	35		0	0	0	0	0	0	68.18	0	0	12.6
2015	7	17	8	14	8	34		0	0	0	0	0	0	68.18	0	0	12.8
2015	7	17	8	24	8	35		0	0	0	0	0	0	68.2	0	0	12.8
2015	7	17	8	34	8	34		0	0	0	0	0	0	68.22	0	0	12.8
2015	7	17	8	44	8	34		0	0	0	0	0	0	68.23	0	0	12.8
2015	7	17	8	54	8	34		0	0	0	0	0	0	68.27	0	0	13
2015	7	17	9	4	8	35		0	0	0	0	0	0	68.29	0	0	13
2015	7	17	9	14	8	35		0	0	0	0	0	0	68.34	0	0	13
2015	7	17	9	24	8	35		0	0	0	0	0	0	68.34	0	0	13.2
2015	7	17	9	34	8	35		0	0	0	0	0	0	68.4	0	0	13
2015	7	17	9	44	8	35		0	0	0	0	0	0	68.43	0	0	13
2015	7	17	9	54	8	35		0	0	0	0	0	0	68.47	0	0	13
2015	7	17	10	4	8	34		0	0	0	0	0	0	68.5	0	0	13
2015	7	17	10	14	8	35		0	0	0	0	0	0	68.54	0	0	13
2015	7	17	10	24	8	35		0	0	0	0	0	0	68.59	0	0	13
2015	7	17	10	34	8	34		0	0	0	0	0	0	68.63	0	0	13
2015	7	17	10	44	8	35		0	0	0	0	0	0	68.65	0	0	13
2015	7	17	10	54	8	35		0	0	0	0	0	0	68.68	0	0	13
2015	7	17	11	4	8	35		0	0	0	0	0	0	68.74	0	0	13
2015	7	17	11	14	8	34		0	0	0	0	0	0	68.77	0	0	13
2015	7	17	11	24	8	34		0	0	0	0	0	0	68.81	0	0	13.2
2015	7	17	11	34	8	35		0	0	0	0	0	0	68.85	0	0	13.2
2015	7	17	11	44	8	35		0	0	0	0	0	0	68.88	0	0	13.2
2015	7	17	11	54	8	35		0	0	0	0	0	0	68.94	0	0	13.2
2015	7	17	12	4	8	35		0	0	0	0	0	0	68.97	0	0	13.2
2015	7	17	12	14	8	35		0	0	0	0	0	0	69.01	0	0	13.2
2015	7	17	12	24	8	35		0	0	0	0	0	0	69.04	0	0	13.2
2015	7	17	12	34	8	35		0	0	0	0	0	0	69.06	0	0	13.2
2015	7	17	12	44	8	35		0	0	0	0	0	0	69.1	0	0	13.2
2015	7	17	12	54	8	35		0	0	0	0	0	0	69.1	0	0	13.2
2015	7	17	13	4	8	35		0	0	0	0	0	0	69.13	0	0	13.2
2015	7	17	13	14	8	34		0	0	0	0	0	0	69.15	0	0	13.2
2015	7	17	13	24	8	35		0	0	0	0	0	0	69.19	0	0	13.2
2015	7	17	13	34	8	35		0	0	0	0	0	0	69.21	0	0	13.2
2015	7	17	13	44	8	35		0	0	0	0	0	0	69.22	0	0	13.2
2015	7	17	13	54	8	35		0	0	0	0	0	0	69.21	0	0	13.2
2015	7	17	14	4	8	34		0	0	0	0	0	0	69.22	0	0	13.2
2015	7	17	14	14	8	35		0	0	0	0	0	0	69.24	0	0	13.2
2015	7	17	14	24	8	34		0	0	0	0	0	0	69.22	0	0	13.2
2015	7	17	14	34	8	35		0	0	0	0	0	0	69.24	0	0	13.2
2015	7	17	14	44	8	35		0	0	0	0	0	0	69.24	0	0	13.2
2015	7	17	14	54	8	35		0	0	0	0	0	0	69.22	0	0	13.2
2015	7	17	15	4	8	35		0	0	0	0	0	0	69.22	0	0	13.2
2015	7	17	15	14	8	35		0	0	0	0	0	0	69.21	0	0	13.2
2015	7	17	15	24	8	34		0	0	0	0	0	0	69.19	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	17	15	34	8	34	0	0	0	0	0	0	0	69.21	0	0	13.2
2015	7	17	15	44	8	35	0	0	0	0	0	0	0	69.21	0	0	13.2
2015	7	17	15	54	8	34	0	0	0	0	0	0	0	69.19	0	0	13.2
2015	7	17	16	4	8	35	0	0	0	0	0	0	0	69.19	0	0	13.2
2015	7	17	16	14	8	35	0	0	0	0	0	0	0	69.17	0	0	13.2
2015	7	17	16	24	8	35	0	0	0	0	0	0	0	69.17	0	0	13.2
2015	7	17	16	34	8	34	0	0	0	0	0	0	0	69.17	0	0	13.2
2015	7	17	16	44	8	35	0	0	0	0	0	0	0	69.17	0	0	13.2
2015	7	17	16	54	8	34	0	0	0	0	0	0	0	69.15	0	0	13.2
2015	7	17	17	4	8	34	0	0	0	0	0	0	0	69.15	0	0	13.2
2015	7	17	17	14	8	35	0	0	0	0	0	0	0	69.12	0	0	13.2
2015	7	17	17	24	8	34	0	0	0	0	0	0	0	69.12	0	0	13.2
2015	7	17	17	34	8	35	0	0	0	0	0	0	0	69.1	0	0	13
2015	7	17	17	44	8	35	0	0	0	0	0	0	0	69.1	0	0	13.2
2015	7	17	17	54	8	34	0	0	0	0	0	0	0	69.1	0	0	13.2
2015	7	17	18	4	8	34	0	0	0	0	0	0	0	69.08	0	0	13.2
2015	7	17	18	14	8	35	0	0	0	0	0	0	0	69.1	0	0	13.2
2015	7	17	18	24	8	35	0	0	0	0	0	0	0	69.12	0	0	13
2015	7	17	18	34	8	35	0	0	0	0	0	0	0	69.13	0	0	12.4
2015	7	17	18	44	8	35	0	0	0	0	0	0	0	69.13	0	0	12.2
2015	7	17	18	54	8	34	0	0	0	0	0	0	0	69.15	0	0	12.2
2015	7	17	19	4	8	35	0	0	0	0	0	0	0	69.17	0	0	12.2
2015	7	17	19	14	8	34	0	0	0	0	0	0	0	69.17	0	0	12.2
2015	7	17	19	24	8	34	0	0	0	0	0	0	0	69.21	0	0	12.2
2015	7	17	19	34	8	34	0	0	0	0	0	0	0	69.21	0	0	12.2
2015	7	17	19	44	8	34	0	0	0	0	0	0	0	69.22	0	0	12.2
2015	7	17	19	54	8	34	0	0	0	0	0	0	0	69.26	0	0	12.2
2015	7	17	20	4	8	35	0	0	0	0	0	0	0	69.28	0	0	12.2
2015	7	17	20	14	8	35	0	0	0	0	0	0	0	69.3	0	0	12.2
2015	7	17	20	24	8	35	0	0	0	0	0	0	0	69.31	0	0	12.2
2015	7	17	20	34	8	35	0	0	0	0	0	0	0	69.35	0	0	12.2
2015	7	17	20	44	8	35	0	0	0	0	0	0	0	69.37	0	0	12.2
2015	7	17	20	54	8	35	0	0	0	0	0	0	0	69.39	0	0	12.2
2015	7	17	21	4	8	35	0	0	0	0	0	0	0	69.4	0	0	12.2
2015	7	17	21	14	8	34	0	0	0	0	0	0	0	69.44	0	0	12.2
2015	7	17	21	24	8	35	0	0	0	0	0	0	0	69.46	0	0	12.2
2015	7	17	21	34	8	35	0	0	0	0	0	0	0	69.48	0	0	12.2
2015	7	17	21	44	8	35	0	0	0	0	0	0	0	69.49	0	0	12.2
2015	7	17	21	54	8	35	0	0	0	0	0	0	0	69.51	0	0	12.2
2015	7	17	22	4	8	34	0	0	0	0	0	0	0	69.53	0	0	12.2
2015	7	17	22	14	8	34	0	0	0	0	0	0	0	69.55	0	0	12.2
2015	7	17	22	24	8	34	0	0	0	0	0	0	0	69.57	0	0	12.2
2015	7	17	22	34	8	34	0	0	0	0	0	0	0	69.57	0	0	12
2015	7	17	22	44	8	34	0	0	0	0	0	0	0	69.58	0	0	12.2
2015	7	17	22	54	8	35	0	0	0	0	0	0	0	69.58	0	0	12.2
2015	7	17	23	4	8	35	0	0	0	0	0	0	0	69.57	0	0	12.2
2015	7	17	23	14	8	34	0	0	0	0	0	0	0	69.57	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	17	23	24	8	34		0	0	0	0	0	0	69.57	0	0	12.2
2015	7	17	23	34	8	35		0	0	0	0	0	0	69.57	0	0	12
2015	7	17	23	44	8	35		0	0	0	0	0	0	69.58	0	0	12.2
2015	7	17	23	54	8	34		0	0	0	0	0	0	69.58	0	0	12
2015	7	18	0	4	8	35		0	0	0	0	0	0	69.58	0	0	12
2015	7	18	0	14	8	34		0	0	0	0	0	0	69.58	0	0	12
2015	7	18	0	24	8	34		0	0	0	0	0	0	69.57	0	0	12
2015	7	18	0	34	8	35		0	0	0	0	0	0	69.57	0	0	12
2015	7	18	0	44	8	35		0	0	0	0	0	0	69.55	0	0	12
2015	7	18	0	54	8	35		0	0	0	0	0	0	69.51	0	0	12
2015	7	18	1	4	8	34		0	0	0	0	0	0	69.49	0	0	12
2015	7	18	1	14	8	34		0	0	0	0	0	0	69.48	0	0	12
2015	7	18	1	24	8	34		0	0	0	0	0	0	69.44	0	0	12
2015	7	18	1	34	8	34		0	0	0	0	0	0	69.44	0	0	12
2015	7	18	1	44	8	34		0	0	0	0	0	0	69.42	0	0	12
2015	7	18	1	54	8	35		0	0	0	0	0	0	69.4	0	0	12
2015	7	18	2	4	8	35		0	0	0	0	0	0	69.39	0	0	12
2015	7	18	2	14	8	35		0	0	0	0	0	0	69.37	0	0	12
2015	7	18	2	24	8	35		0	0	0	0	0	0	69.35	0	0	12
2015	7	18	2	34	8	34		0	0	0	0	0	0	69.33	0	0	12
2015	7	18	2	44	8	35		0	0	0	0	0	0	69.31	0	0	12
2015	7	18	2	54	8	34		0	0	0	0	0	0	69.28	0	0	12
2015	7	18	3	4	8	34		0	0	0	0	0	0	69.24	0	0	12
2015	7	18	3	14	8	35		0	0	0	0	0	0	69.21	0	0	12
2015	7	18	3	24	8	35		0	0	0	0	0	0	69.19	0	0	12
2015	7	18	3	34	8	34		0	0	0	0	0	0	69.13	0	0	12
2015	7	18	3	44	8	35		0	0	0	0	0	0	69.12	0	0	12
2015	7	18	3	54	8	34		0	0	0	0	0	0	69.08	0	0	12
2015	7	18	4	4	8	35		0	0	0	0	0	0	69.03	0	0	12
2015	7	18	4	14	8	34		0	0	0	0	0	0	68.97	0	0	12
2015	7	18	4	24	8	34		0	0	0	0	0	0	68.94	0	0	12
2015	7	18	4	34	8	35		0	0	0	0	0	0	68.88	0	0	12
2015	7	18	4	44	8	34		0	0	0	0	0	0	68.85	0	0	12
2015	7	18	4	54	8	35		0	0	0	0	0	0	68.79	0	0	12
2015	7	18	5	4	8	35		0	0	0	0	0	0	68.74	0	0	12
2015	7	18	5	14	8	35		0	0	0	0	0	0	68.7	0	0	12
2015	7	18	5	24	8	35		0	0	0	0	0	0	68.65	0	0	12
2015	7	18	5	34	8	34		0	0	0	0	0	0	68.61	0	0	12
2015	7	18	5	44	8	35		0	0	0	0	0	0	68.58	0	0	12
2015	7	18	5	54	8	35		0	0	0	0	0	0	68.52	0	0	12
2015	7	18	6	4	8	35		0	0	0	0	0	0	68.47	0	0	12
2015	7	18	6	14	8	35		0	0	0	0	0	0	68.43	0	0	12
2015	7	18	6	24	8	34		0	0	0	0	0	0	68.4	0	0	12
2015	7	18	6	34	8	35		0	0	0	0	0	0	68.36	0	0	12
2015	7	18	6	44	8	35		0	0	0	0	0	0	68.31	0	0	12
2015	7	18	6	54	8	34		0	0	0	0	0	0	68.27	0	0	12
2015	7	18	7	4	8	35		0	0	0	0	0	0	68.23	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	18	7	14	8	35		0	0	0	0	0	0	68.2	0	0	12.2
2015	7	18	7	24	8	35		0	0	0	0	0	0	68.22	0	0	12.4
2015	7	18	7	34	8	35		0	0	0	0	0	0	68.2	0	0	12.4
2015	7	18	7	44	8	35		0	0	0	0	0	0	68.18	0	0	12.6
2015	7	18	7	54	8	35		0	0	0	0	0	0	68.18	0	0	12.6
2015	7	18	8	4	8	35		0	0	0	0	0	0	68.18	0	0	12.6
2015	7	18	8	14	8	34		0	0	0	0	0	0	68.2	0	0	12.8
2015	7	18	8	24	8	34		0	0	0	0	0	0	68.2	0	0	12.8
2015	7	18	8	34	8	35		0	0	0	0	0	0	68.2	0	0	12.8
2015	7	18	8	44	8	35		0	0	0	0	0	0	68.22	0	0	12.8
2015	7	18	8	54	8	35		0	0	0	0	0	0	68.23	0	0	12.8
2015	7	18	9	4	8	35		0	0	0	0	0	0	68.23	0	0	13
2015	7	18	9	14	8	34		0	0	0	0	0	0	68.25	0	0	13
2015	7	18	9	24	8	35		0	0	0	0	0	0	68.29	0	0	13.2
2015	7	18	9	34	8	34		0	0	0	0	0	0	68.31	0	0	13
2015	7	18	9	44	8	34		0	0	0	0	0	0	68.32	0	0	13.2
2015	7	18	9	54	8	34		0	0	0	0	0	0	68.38	0	0	13.2
2015	7	18	10	4	8	35		0	0	0	0	0	0	68.41	0	0	13
2015	7	18	10	14	8	34		0	0	0	0	0	0	68.45	0	0	13
2015	7	18	10	24	8	35		0	0	0	0	0	0	68.49	0	0	13.2
2015	7	18	10	34	8	35		0	0	0	0	0	0	68.52	0	0	13
2015	7	18	10	44	8	35		0	0	0	0	0	0	68.56	0	0	13.2
2015	7	18	10	54	8	34		0	0	0	0	0	0	68.59	0	0	13.2
2015	7	18	11	4	8	34		0	0	0	0	0	0	68.63	0	0	13.2
2015	7	18	11	14	8	35		0	0	0	0	0	0	68.67	0	0	13.2
2015	7	18	11	24	8	35		0	0	0	0	0	0	68.7	0	0	13.2
2015	7	18	11	34	8	34		0	0	0	0	0	0	68.74	0	0	13.2
2015	7	18	11	44	8	35		0	0	0	0	0	0	68.77	0	0	13.2
2015	7	18	11	54	8	35		0	0	0	0	0	0	68.79	0	0	13.2
2015	7	18	12	4	8	34		0	0	0	0	0	0	68.83	0	0	13.2
2015	7	18	12	14	8	34		0	0	0	0	0	0	68.86	0	0	13.2
2015	7	18	12	24	8	34		0	0	0	0	0	0	68.9	0	0	13.2
2015	7	18	12	34	8	35		0	0	0	0	0	0	68.92	0	0	13.2
2015	7	18	12	44	8	35		0	0	0	0	0	0	68.99	0	0	13.2
2015	7	18	12	54	8	34		0	0	0	0	0	0	68.99	0	0	13.2
2015	7	18	13	4	8	35		0	0	0	0	0	0	69.01	0	0	13.2
2015	7	18	13	14	8	35		0	0	0	0	0	0	68.85	0	0	13.2
2015	7	18	13	24	8	35		0	0	0	0	0	0	68.92	0	0	13.2
2015	7	18	13	34	8	34		0	0	0	0	0	0	68.74	0	0	13
2015	7	18	13	44	8	34		0	0	0	0	0	0	68.74	0	0	13.2
2015	7	18	13	54	8	35		0	0	0	0	0	0	68.77	0	0	13.2
2015	7	18	14	4	8	35		0	0	0	0	0	0	68.72	0	0	13.2
2015	7	18	14	14	8	35		0	0	0	0	0	0	68.72	0	0	13.4
2015	7	18	14	24	8	35		0	0	0	0	0	0	68.61	0	0	13.4
2015	7	18	14	34	8	35		0	0	0	0	0	0	68.68	0	0	13.4
2015	7	18	14	44	8	34		0	0	0	0	0	0	68.61	0	0	13.4
2015	7	18	14	54	8	35		0	0	0	0	0	0	68.56	0	0	13.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	18	15	4	8	35	0	0	0	0	0	0	0	68.56	0	0	13.4
2015	7	18	15	14	8	34	0	0	0	0	0	0	0	68.68	0	0	13.4
2015	7	18	15	24	8	34	0	0	0	0	0	0	0	68.7	0	0	13.4
2015	7	18	15	34	8	35	0	0	0	0	0	0	0	68.72	0	0	13.4
2015	7	18	15	44	8	35	0	0	0	0	0	0	0	68.7	0	0	13.4
2015	7	18	15	54	8	34	0	0	0	0	0	0	0	68.72	0	0	13.4
2015	7	18	16	4	8	35	0	0	0	0	0	0	0	68.74	0	0	13.4
2015	7	18	16	14	8	34	0	0	0	0	0	0	0	68.72	0	0	13.4
2015	7	18	16	24	8	34	0	0	0	0	0	0	0	68.74	0	0	13.4
2015	7	18	16	34	8	35	0	0	0	0	0	0	0	68.67	0	0	13.2
2015	7	18	16	44	8	35	0	0	0	0	0	0	0	68.59	0	0	13.4
2015	7	18	16	54	8	35	0	0	0	0	0	0	0	68.54	0	0	12.6
2015	7	18	17	4	8	34	0	0	0	0	0	0	0	68.5	0	0	12.2
2015	7	18	17	14	8	34	0	0	0	0	0	0	0	68.49	0	0	12.2
2015	7	18	17	24	8	34	0	0	0	0	0	0	0	68.47	0	0	12.2
2015	7	18	17	34	8	35	0	0	0	0	0	0	0	68.45	0	0	12.2
2015	7	18	17	44	8	35	0	0	0	0	0	0	0	68.45	0	0	12.2
2015	7	18	17	54	8	35	0	0	0	0	0	0	0	68.45	0	0	12.2
2015	7	18	18	4	8	35	0	0	0	0	0	0	0	68.45	0	0	12.2
2015	7	18	18	14	8	35	0	0	0	0	0	0	0	68.45	0	0	12.2
2015	7	18	18	24	8	34	0	0	0	0	0	0	0	68.45	0	0	12.2
2015	7	18	18	34	8	34	0	0	0	0	0	0	0	68.47	0	0	12.2
2015	7	18	18	44	8	35	0	0	0	0	0	0	0	68.5	0	0	12.2
2015	7	18	18	54	8	35	0	0	0	0	0	0	0	68.52	0	0	12.2
2015	7	18	19	4	8	35	0	0	0	0	0	0	0	68.52	0	0	12.2
2015	7	18	19	14	8	35	0	0	0	0	0	0	0	68.52	0	0	12.2
2015	7	18	19	24	8	35	0	0	0	0	0	0	0	68.52	0	0	12.2
2015	7	18	19	34	8	35	0	0	0	0	0	0	0	68.54	0	0	12.2
2015	7	18	19	44	8	35	0	0	0	0	0	0	0	68.54	0	0	12.2
2015	7	18	19	54	8	34	0	0	0	0	0	0	0	68.56	0	0	12.2
2015	7	18	20	4	8	35	0	0	0	0	0	0	0	68.56	0	0	12.2
2015	7	18	20	14	8	34	0	0	0	0	0	0	0	68.56	0	0	12.2
2015	7	18	20	24	8	35	0	0	0	0	0	0	0	68.58	0	0	12.2
2015	7	18	20	34	8	35	0	0	0	0	0	0	0	68.59	0	0	12.2
2015	7	18	20	44	8	34	0	0	0	0	0	0	0	68.61	0	0	12.2
2015	7	18	20	54	8	35	0	0	0	0	0	0	0	68.61	0	0	12.2
2015	7	18	21	4	8	34	0	0	0	0	0	0	0	68.63	0	0	12.2
2015	7	18	21	14	8	35	0	0	0	0	0	0	0	68.65	0	0	12.2
2015	7	18	21	24	8	35	0	0	0	0	0	0	0	68.65	0	0	12.2
2015	7	18	21	34	8	35	0	0	0	0	0	0	0	68.65	0	0	12
2015	7	18	21	44	8	35	0	0	0	0	0	0	0	68.67	0	0	12
2015	7	18	21	54	8	34	0	0	0	0	0	0	0	68.68	0	0	12
2015	7	18	22	4	8	34	0	0	0	0	0	0	0	68.68	0	0	12
2015	7	18	22	14	8	35	0	0	0	0	0	0	0	68.68	0	0	12
2015	7	18	22	24	8	34	0	0	0	0	0	0	0	68.7	0	0	12
2015	7	18	22	34	8	35	0	0	0	0	0	0	0	68.68	0	0	12
2015	7	18	22	44	8	34	0	0	0	0	0	0	0	68.7	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	18	22	54	8	34	0	0	0	0	0	0	0	68.7	0	0	12
2015	7	18	23	4	8	35	0	0	0	0	0	0	0	68.7	0	0	12
2015	7	18	23	14	8	34	0	0	0	0	0	0	0	68.7	0	0	12
2015	7	18	23	24	8	35	0	0	0	0	0	0	0	68.68	0	0	12
2015	7	18	23	34	8	35	0	0	0	0	0	0	0	68.68	0	0	12
2015	7	18	23	44	8	34	0	0	0	0	0	0	0	68.67	0	0	12
2015	7	18	23	54	8	35	0	0	0	0	0	0	0	68.67	0	0	12
2015	7	19	0	4	8	35	0	0	0	0	0	0	0	68.65	0	0	12
2015	7	19	0	14	8	35	0	0	0	0	0	0	0	68.63	0	0	12
2015	7	19	0	24	8	35	0	0	0	0	0	0	0	68.61	0	0	12
2015	7	19	0	34	8	34	0	0	0	0	0	0	0	68.59	0	0	12
2015	7	19	0	44	8	35	0	0	0	0	0	0	0	68.56	0	0	12
2015	7	19	0	54	8	35	0	0	0	0	0	0	0	68.54	0	0	12
2015	7	19	1	4	8	35	0	0	0	0	0	0	0	68.52	0	0	12
2015	7	19	1	14	8	35	0	0	0	0	0	0	0	68.5	0	0	12
2015	7	19	1	24	8	36	0	0	0	0	0	0	0	68.45	0	0	12
2015	7	19	1	34	8	35	0	0	0	0	0	0	0	68.43	0	0	12
2015	7	19	1	44	8	34	0	0	0	0	0	0	0	68.4	0	0	12
2015	7	19	1	54	8	35	0	0	0	0	0	0	0	68.38	0	0	12
2015	7	19	2	4	8	35	0	0	0	0	0	0	0	68.34	0	0	12
2015	7	19	2	14	8	35	0	0	0	0	0	0	0	68.31	0	0	12
2015	7	19	2	24	8	35	0	0	0	0	0	0	0	68.29	0	0	12
2015	7	19	2	34	8	35	0	0	0	0	0	0	0	68.23	0	0	12
2015	7	19	2	44	8	35	0	0	0	0	0	0	0	68.22	0	0	12
2015	7	19	2	54	8	35	0	0	0	0	0	0	0	68.18	0	0	12
2015	7	19	3	4	8	35	0	0	0	0	0	0	0	68.13	0	0	12
2015	7	19	3	14	8	35	0	0	0	0	0	0	0	68.09	0	0	12
2015	7	19	3	24	8	35	0	0	0	0	0	0	0	68.04	0	0	12
2015	7	19	3	34	8	35	0	0	0	0	0	0	0	68.02	0	0	12
2015	7	19	3	44	8	35	0	0	0	0	0	0	0	67.98	0	0	12
2015	7	19	3	54	8	35	0	0	0	0	0	0	0	67.93	0	0	12
2015	7	19	4	4	8	35	0	0	0	0	0	0	0	67.89	0	0	12
2015	7	19	4	14	8	34	0	0	0	0	0	0	0	67.86	0	0	12
2015	7	19	4	24	8	34	0	0	0	0	0	0	0	67.82	0	0	12
2015	7	19	4	34	8	35	0	0	0	0	0	0	0	67.78	0	0	11.8
2015	7	19	4	44	8	35	0	0	0	0	0	0	0	67.75	0	0	12
2015	7	19	4	54	8	35	0	0	0	0	0	0	0	67.73	0	0	12
2015	7	19	5	4	8	35	0	0	0	0	0	0	0	67.69	0	0	12
2015	7	19	5	14	8	34	0	0	0	0	0	0	0	67.66	0	0	12
2015	7	19	5	24	8	35	0	0	0	0	0	0	0	67.62	0	0	12
2015	7	19	5	34	8	35	0	0	0	0	0	0	0	67.6	0	0	11.8
2015	7	19	5	44	8	35	0	0	0	0	0	0	0	67.57	0	0	12
2015	7	19	5	54	8	35	0	0	0	0	0	0	0	67.55	0	0	12
2015	7	19	6	4	8	35	0	0	0	0	0	0	0	67.51	0	0	12
2015	7	19	6	14	8	35	0	0	0	0	0	0	0	67.5	0	0	12
2015	7	19	6	24	8	35	0	0	0	0	0	0	0	67.48	0	0	12
2015	7	19	6	34	8	35	0	0	0	0	0	0	0	67.46	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	19	6	44	8	35		0	0	0	0	0	0	67.44	0	0	12
2015	7	19	6	54	8	35		0	0	0	0	0	0	67.44	0	0	12
2015	7	19	7	4	8	35		0	0	0	0	0	0	67.42	0	0	12
2015	7	19	7	14	8	35		0	0	0	0	0	0	67.42	0	0	12
2015	7	19	7	24	8	35		0	0	0	0	0	0	67.44	0	0	12.2
2015	7	19	7	34	8	35		0	0	0	0	0	0	67.44	0	0	12.2
2015	7	19	7	44	8	35		0	0	0	0	0	0	67.46	0	0	12.6
2015	7	19	7	54	8	34		0	0	0	0	0	0	67.44	0	0	12.6
2015	7	19	8	4	8	35		0	0	0	0	0	0	67.5	0	0	12.8
2015	7	19	8	14	8	35		0	0	0	0	0	0	67.53	0	0	12.8
2015	7	19	8	24	8	35		0	0	0	0	0	0	67.55	0	0	12.8
2015	7	19	8	34	8	34		0	0	0	0	0	0	67.57	0	0	12.8
2015	7	19	8	44	8	34		0	0	0	0	0	0	67.6	0	0	12.8
2015	7	19	8	54	8	34		0	0	0	0	0	0	67.62	0	0	13
2015	7	19	9	4	8	34		0	0	0	0	0	0	67.66	0	0	13
2015	7	19	9	14	8	35		0	0	0	0	0	0	67.69	0	0	13
2015	7	19	9	24	8	35		0	0	0	0	0	0	67.71	0	0	13.2
2015	7	19	9	34	8	34		0	0	0	0	0	0	67.73	0	0	13.2
2015	7	19	9	44	8	36		0	0	0	0	0	0	67.77	0	0	13.2
2015	7	19	9	54	8	34		0	0	0	0	0	0	67.8	0	0	13.2
2015	7	19	10	4	8	36		0	0	0	0	0	0	67.82	0	0	13.2
2015	7	19	10	14	8	34		0	0	0	0	0	0	67.86	0	0	13.2
2015	7	19	10	24	8	35		0	0	0	0	0	0	67.91	0	0	13.2
2015	7	19	10	34	8	35		0	0	0	0	0	0	67.98	0	0	13.2
2015	7	19	10	44	8	35		0	0	0	0	0	0	68.02	0	0	13.2
2015	7	19	10	54	8	34		0	0	0	0	0	0	68.04	0	0	13.2
2015	7	19	11	4	8	34		0	0	0	0	0	0	68.05	0	0	13.2
2015	7	19	11	14	8	35		0	0	0	0	0	0	68.11	0	0	13.2
2015	7	19	11	24	8	35		0	0	0	0	0	0	68.13	0	0	13.2
2015	7	19	11	34	8	34		0	0	0	0	0	0	68.05	0	0	13.2
2015	7	19	11	44	8	34		0	0	0	0	0	0	68.11	0	0	13.2
2015	7	19	11	54	8	34		0	0	0	0	0	0	68.09	0	0	13.2
2015	7	19	12	4	8	35		0	0	0	0	0	0	68.04	0	0	13.2
2015	7	19	12	14	8	35		0	0	0	0	0	0	68.04	0	0	13.2
2015	7	19	12	24	8	35		0	0	0	0	0	0	68.27	0	0	13.2
2015	7	19	12	34	8	35		0	0	0	0	0	0	68.18	0	0	13.2
2015	7	19	12	44	8	35		0	0	0	0	0	0	68.07	0	0	13.2
2015	7	19	12	54	8	34		0	0	0	0	0	0	68.16	0	0	13.2
2015	7	19	13	4	8	34		0	0	0	0	0	0	68.31	0	0	13.2
2015	7	19	13	14	8	35		0	0	0	0	0	0	68.43	0	0	13.2
2015	7	19	13	24	8	34		0	0	0	0	0	0	68.45	0	0	13.2
2015	7	19	13	34	8	35		0	0	0	0	0	0	68.43	0	0	13.2
2015	7	19	13	44	8	35		0	0	0	0	0	0	68.47	0	0	13.2
2015	7	19	13	54	8	35		0	0	0	0	0	0	68.38	0	0	13.2
2015	7	19	14	4	8	35		0	0	0	0	0	0	68.29	0	0	13.2
2015	7	19	14	14	8	34		0	0	0	0	0	0	68.29	0	0	13.2
2015	7	19	14	24	8	35		0	0	0	0	0	0	68.38	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	19	14	34	8	35		0	0	0	0	0	0	68.41	0	0	13.2
2015	7	19	14	44	8	35		0	0	0	0	0	0	68.36	0	0	13.2
2015	7	19	14	54	8	35		0	0	0	0	0	0	68.43	0	0	13.2
2015	7	19	15	4	8	34		0	0	0	0	0	0	68.45	0	0	13.2
2015	7	19	15	14	8	35		0	0	0	0	0	0	68.47	0	0	13.2
2015	7	19	15	24	8	34		0	0	0	0	0	0	68.47	0	0	13
2015	7	19	15	34	8	35		0	0	0	0	0	0	68.47	0	0	13
2015	7	19	15	44	8	35		0	0	0	0	0	0	68.49	0	0	13
2015	7	19	15	54	8	35		0	0	0	0	0	0	68.49	0	0	13
2015	7	19	16	4	8	35		0	0	0	0	0	0	68.45	0	0	13
2015	7	19	16	14	8	35		0	0	0	0	0	0	68.45	0	0	13
2015	7	19	16	24	8	35		0	0	0	0	0	0	68.45	0	0	13
2015	7	19	16	34	8	35		0	0	0	0	0	0	68.45	0	0	13
2015	7	19	16	44	8	34		0	0	0	0	0	0	68.47	0	0	13
2015	7	19	16	54	8	34		0	0	0	0	0	0	68.47	0	0	13
2015	7	19	17	4	8	35		0	0	0	0	0	0	68.45	0	0	13
2015	7	19	17	14	8	35		0	0	0	0	0	0	68.47	0	0	13
2015	7	19	17	24	8	35		0	0	0	0	0	0	68.47	0	0	13.2
2015	7	19	17	34	8	35		0	0	0	0	0	0	68.47	0	0	13.2
2015	7	19	17	44	8	35		0	0	0	0	0	0	68.45	0	0	13.2
2015	7	19	17	54	8	35		0	0	0	0	0	0	68.41	0	0	13.2
2015	7	19	18	4	8	35		0	0	0	0	0	0	68.45	0	0	13.2
2015	7	19	18	14	8	34		0	0	0	0	0	0	68.45	0	0	12.4
2015	7	19	18	24	8	35		0	0	0	0	0	0	68.45	0	0	12.2
2015	7	19	18	34	8	34		0	0	0	0	0	0	68.49	0	0	12.2
2015	7	19	18	44	8	35		0	0	0	0	0	0	68.52	0	0	12.4
2015	7	19	18	54	8	35		0	0	0	0	0	0	68.54	0	0	13
2015	7	19	19	4	8	35		0	0	0	0	0	0	68.56	0	0	12.4
2015	7	19	19	14	8	34		0	0	0	0	0	0	68.59	0	0	12.2
2015	7	19	19	24	8	34		0	0	0	0	0	0	68.59	0	0	12.2
2015	7	19	19	34	8	35		0	0	0	0	0	0	68.63	0	0	12.2
2015	7	19	19	44	8	34		0	0	0	0	0	0	68.63	0	0	12.2
2015	7	19	19	54	8	35		0	0	0	0	0	0	68.65	0	0	12.2
2015	7	19	20	4	8	35		0	0	0	0	0	0	68.68	0	0	12.2
2015	7	19	20	14	8	35		0	0	0	0	0	0	68.7	0	0	12.2
2015	7	19	20	24	8	34		0	0	0	0	0	0	68.72	0	0	12.2
2015	7	19	20	34	8	35		0	0	0	0	0	0	68.76	0	0	12.2
2015	7	19	20	44	8	34		0	0	0	0	0	0	68.77	0	0	12.2
2015	7	19	20	54	8	35		0	0	0	0	0	0	68.81	0	0	12.2
2015	7	19	21	4	8	35		0	0	0	0	0	0	68.83	0	0	12.2
2015	7	19	21	14	8	35		0	0	0	0	0	0	68.86	0	0	12.2
2015	7	19	21	24	8	35		0	0	0	0	0	0	68.88	0	0	12.2
2015	7	19	21	34	8	34		0	0	0	0	0	0	68.92	0	0	12.2
2015	7	19	21	44	8	34		0	0	0	0	0	0	68.94	0	0	12.2
2015	7	19	21	54	8	35		0	0	0	0	0	0	68.95	0	0	12.2
2015	7	19	22	4	8	35		0	0	0	0	0	0	68.97	0	0	12.2
2015	7	19	22	14	8	35		0	0	0	0	0	0	69.01	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	19	22	24	8	35	0	0	0	0	0	0	0	69.03	0	0	12.2
2015	7	19	22	34	8	35	0	0	0	0	0	0	0	69.04	0	0	12
2015	7	19	22	44	8	35	0	0	0	0	0	0	0	69.08	0	0	12.2
2015	7	19	22	54	8	34	0	0	0	0	0	0	0	69.08	0	0	12.2
2015	7	19	23	4	8	35	0	0	0	0	0	0	0	69.12	0	0	12.2
2015	7	19	23	14	8	34	0	0	0	0	0	0	0	69.12	0	0	12.2
2015	7	19	23	24	8	35	0	0	0	0	0	0	0	69.13	0	0	12.2
2015	7	19	23	34	8	35	0	0	0	0	0	0	0	69.17	0	0	12
2015	7	19	23	44	8	35	0	0	0	0	0	0	0	69.19	0	0	12.2
2015	7	19	23	54	8	35	0	0	0	0	0	0	0	69.19	0	0	12
2015	7	20	0	4	8	34	0	0	0	0	0	0	0	69.21	0	0	12
2015	7	20	0	14	8	34	0	0	0	0	0	0	0	69.22	0	0	12
2015	7	20	0	24	8	34	0	0	0	0	0	0	0	69.24	0	0	12
2015	7	20	0	34	8	35	0	0	0	0	0	0	0	69.24	0	0	12
2015	7	20	0	44	8	34	0	0	0	0	0	0	0	69.24	0	0	12
2015	7	20	0	54	8	35	0	0	0	0	0	0	0	69.24	0	0	12
2015	7	20	1	4	8	34	0	0	0	0	0	0	0	69.24	0	0	12
2015	7	20	1	14	8	34	0	0	0	0	0	0	0	69.24	0	0	12
2015	7	20	1	24	8	35	0	0	0	0	0	0	0	69.24	0	0	12
2015	7	20	1	34	8	34	0	0	0	0	0	0	0	69.24	0	0	12
2015	7	20	1	44	8	34	0	0	0	0	0	0	0	69.22	0	0	12
2015	7	20	1	54	8	34	0	0	0	0	0	0	0	69.22	0	0	12
2015	7	20	2	4	8	35	0	0	0	0	0	0	0	69.21	0	0	12
2015	7	20	2	14	8	34	0	0	0	0	0	0	0	69.19	0	0	12
2015	7	20	2	24	8	35	0	0	0	0	0	0	0	69.19	0	0	12
2015	7	20	2	34	8	35	0	0	0	0	0	0	0	69.17	0	0	12
2015	7	20	2	44	8	34	0	0	0	0	0	0	0	69.15	0	0	12
2015	7	20	2	54	8	34	0	0	0	0	0	0	0	69.13	0	0	12
2015	7	20	3	4	8	35	0	0	0	0	0	0	0	69.12	0	0	12
2015	7	20	3	14	8	34	0	0	0	0	0	0	0	69.12	0	0	12
2015	7	20	3	24	8	34	0	0	0	0	0	0	0	69.08	0	0	12
2015	7	20	3	34	8	36	0	0	0	0	0	0	0	69.06	0	0	12
2015	7	20	3	44	8	35	0	0	0	0	0	0	0	69.04	0	0	12
2015	7	20	3	54	8	35	0	0	0	0	0	0	0	69.03	0	0	12
2015	7	20	4	4	8	35	0	0	0	0	0	0	0	69.01	0	0	12
2015	7	20	4	14	8	34	0	0	0	0	0	0	0	68.99	0	0	12
2015	7	20	4	24	8	35	0	0	0	0	0	0	0	68.97	0	0	12
2015	7	20	4	34	8	34	0	0	0	0	0	0	0	68.95	0	0	12
2015	7	20	4	44	8	35	0	0	0	0	0	0	0	68.94	0	0	12
2015	7	20	4	54	8	34	0	0	0	0	0	0	0	68.92	0	0	12
2015	7	20	5	4	8	34	0	0	0	0	0	0	0	68.9	0	0	12
2015	7	20	5	14	8	35	0	0	0	0	0	0	0	68.86	0	0	12
2015	7	20	5	24	8	34	0	0	0	0	0	0	0	68.86	0	0	12
2015	7	20	5	34	8	35	0	0	0	0	0	0	0	68.83	0	0	12
2015	7	20	5	44	8	34	0	0	0	0	0	0	0	68.83	0	0	12
2015	7	20	5	54	8	34	0	0	0	0	0	0	0	68.79	0	0	12
2015	7	20	6	4	8	35	0	0	0	0	0	0	0	68.77	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	20	6	14	8	34		0	0	0	0	0	0	68.77	0	0	12
2015	7	20	6	24	8	35		0	0	0	0	0	0	68.76	0	0	12
2015	7	20	6	34	8	35		0	0	0	0	0	0	68.74	0	0	12
2015	7	20	6	44	8	35		0	0	0	0	0	0	68.72	0	0	12
2015	7	20	6	54	8	35		0	0	0	0	0	0	68.7	0	0	12
2015	7	20	7	4	8	35		0	0	0	0	0	0	68.7	0	0	12
2015	7	20	7	14	8	35		0	0	0	0	0	0	68.68	0	0	12
2015	7	20	7	24	8	34		0	0	0	0	0	0	68.68	0	0	12
2015	7	20	7	34	8	34		0	0	0	0	0	0	68.67	0	0	12
2015	7	20	7	44	8	34		0	0	0	0	0	0	68.65	0	0	12
2015	7	20	7	54	8	35		0	0	0	0	0	0	68.65	0	0	12
2015	7	20	8	4	8	34		0	0	0	0	0	0	68.65	0	0	12.2
2015	7	20	8	14	8	34		0	0	0	0	0	0	68.65	0	0	12.2
2015	7	20	8	24	8	35		0	0	0	0	0	0	68.67	0	0	12.4
2015	7	20	8	34	8	34		0	0	0	0	0	0	68.67	0	0	12.4
2015	7	20	8	44	8	35		0	0	0	0	0	0	68.67	0	0	12.6
2015	7	20	8	54	8	35		0	0	0	0	0	0	68.67	0	0	12.6
2015	7	20	9	4	8	35		0	0	0	0	0	0	68.67	0	0	12.6
2015	7	20	9	14	8	34		0	0	0	0	0	0	68.67	0	0	12.6
2015	7	20	9	24	8	34		0	0	0	0	0	0	68.67	0	0	12.6
2015	7	20	9	34	8	34		0	0	0	0	0	0	68.67	0	0	12.6
2015	7	20	9	44	8	35		0	0	0	0	0	0	68.67	0	0	12.6
2015	7	20	9	54	8	35		0	0	0	0	0	0	68.67	0	0	12.6
2015	7	20	10	4	8	35		0	0	0	0	0	0	68.68	0	0	12.8
2015	7	20	10	14	8	35		0	0	0	0	0	0	68.68	0	0	12.6
2015	7	20	10	24	8	34		0	0	0	0	0	0	68.7	0	0	12.8
2015	7	20	10	34	8	34		0	0	0	0	0	0	68.74	0	0	12.8
2015	7	20	10	44	8	35		0	0	0	0	0	0	68.74	0	0	12.8
2015	7	20	10	54	8	35		0	0	0	0	0	0	68.74	0	0	12.8
2015	7	20	11	4	8	35		0	0	0	0	0	0	68.79	0	0	13.2
2015	7	20	11	14	8	35		0	0	0	0	0	0	68.92	0	0	13.4
2015	7	20	11	24	8	35		0	0	0	0	0	0	68.95	0	0	13.4
2015	7	20	11	34	8	34		0	0	0	0	0	0	68.81	0	0	12.8
2015	7	20	11	44	8	34		0	0	0	0	0	0	68.99	0	0	13.4
2015	7	20	11	54	8	35		0	0	0	0	0	0	69.15	0	0	13.4
2015	7	20	12	4	8	34		0	0	0	0	0	0	69.17	0	0	13.4
2015	7	20	12	14	8	34		0	0	0	0	0	0	69.21	0	0	13.2
2015	7	20	12	24	8	34		0	0	0	0	0	0	69.28	0	0	13.2
2015	7	20	12	34	8	36		0	0	0	0	0	0	69.33	0	0	13.2
2015	7	20	12	44	8	34		0	0	0	0	0	0	69.26	0	0	13.2
2015	7	20	12	54	8	34		0	0	0	0	0	0	69.28	0	0	13.2
2015	7	20	13	4	8	35		0	0	0	0	0	0	69.22	0	0	13.2
2015	7	20	13	14	8	35		0	0	0	0	0	0	69.31	0	0	13.2
2015	7	20	13	24	8	35		0	0	0	0	0	0	69.28	0	0	13.2
2015	7	20	13	34	8	34		0	0	0	0	0	0	69.26	0	0	13.2
2015	7	20	13	44	8	35		0	0	0	0	0	0	69.13	0	0	13.2
2015	7	20	13	54	8	34		0	0	0	0	0	0	69.08	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	20	14	4	8	34	0	0	0	0	0	0	0	69.08	0	0	13.2
2015	7	20	14	14	8	35	0	0	0	0	0	0	0	69.13	0	0	13.2
2015	7	20	14	24	8	35	0	0	0	0	0	0	0	69.17	0	0	13.4
2015	7	20	14	34	8	34	0	0	0	0	0	0	0	69.17	0	0	13.2
2015	7	20	14	44	8	35	0	0	0	0	0	0	0	69.15	0	0	13.4
2015	7	20	14	54	8	35	0	0	0	0	0	0	0	69.17	0	0	13.4
2015	7	20	15	4	8	35	0	0	0	0	0	0	0	69.17	0	0	13.4
2015	7	20	15	14	8	35	0	0	0	0	0	0	0	69.19	0	0	13.4
2015	7	20	15	24	8	34	0	0	0	0	0	0	0	69.12	0	0	13.4
2015	7	20	15	34	8	34	0	0	0	0	0	0	0	69.13	0	0	13.2
2015	7	20	15	44	8	35	0	0	0	0	0	0	0	69.28	0	0	13.4
2015	7	20	15	54	8	34	0	0	0	0	0	0	0	69.19	0	0	13.2
2015	7	20	16	4	8	34	0	0	0	0	0	0	0	69.12	0	0	13.2
2015	7	20	16	14	8	35	0	0	0	0	0	0	0	69.1	0	0	13.2
2015	7	20	16	24	8	35	0	0	0	0	0	0	0	69.08	0	0	13.2
2015	7	20	16	34	8	35	0	0	0	0	0	0	0	69.04	0	0	13
2015	7	20	16	44	8	34	0	0	0	0	0	0	0	69.06	0	0	13.4
2015	7	20	16	54	8	35	0	0	0	0	0	0	0	69.08	0	0	13.4
2015	7	20	17	4	8	34	0	0	0	0	0	0	0	69.08	0	0	13.4
2015	7	20	17	14	8	35	0	0	0	0	0	0	0	69.08	0	0	13.4
2015	7	20	17	24	8	35	0	0	0	0	0	0	0	69.08	0	0	13.4
2015	7	20	17	34	8	35	0	0	0	0	0	0	0	69.12	0	0	13.2
2015	7	20	17	44	8	34	0	0	0	0	0	0	0	69.15	0	0	13.4
2015	7	20	17	54	8	34	0	0	0	0	0	0	0	69.17	0	0	13.4
2015	7	20	18	4	8	35	0	0	0	0	0	0	0	69.19	0	0	13.4
2015	7	20	18	14	8	35	0	0	0	0	0	0	0	69.19	0	0	13
2015	7	20	18	24	8	35	0	0	0	0	0	0	0	69.17	0	0	12.2
2015	7	20	18	34	8	34	0	0	0	0	0	0	0	69.19	0	0	12.2
2015	7	20	18	44	8	35	0	0	0	0	0	0	0	69.19	0	0	12.2
2015	7	20	18	54	8	34	0	0	0	0	0	0	0	69.21	0	0	12.2
2015	7	20	19	4	8	35	0	0	0	0	0	0	0	69.22	0	0	12.2
2015	7	20	19	14	8	34	0	0	0	0	0	0	0	69.24	0	0	12.2
2015	7	20	19	24	8	34	0	0	0	0	0	0	0	69.26	0	0	12.2
2015	7	20	19	34	8	35	0	0	0	0	0	0	0	69.28	0	0	12.2
2015	7	20	19	44	8	35	0	0	0	0	0	0	0	69.31	0	0	12.2
2015	7	20	19	54	8	34	0	0	0	0	0	0	0	69.33	0	0	12.2
2015	7	20	20	4	8	34	0	0	0	0	0	0	0	69.35	0	0	12.2
2015	7	20	20	14	8	35	0	0	0	0	0	0	0	69.39	0	0	12.2
2015	7	20	20	24	8	35	0	0	0	0	0	0	0	69.4	0	0	12.2
2015	7	20	20	34	8	35	0	0	0	0	0	0	0	69.44	0	0	12.2
2015	7	20	20	44	8	35	0	0	0	0	0	0	0	69.44	0	0	12.2
2015	7	20	20	54	8	35	0	0	0	0	0	0	0	69.48	0	0	12.2
2015	7	20	21	4	8	35	0	0	0	0	0	0	0	69.49	0	0	12.2
2015	7	20	21	14	8	35	0	0	0	0	0	0	0	69.51	0	0	12.2
2015	7	20	21	24	8	35	0	0	0	0	0	0	0	69.53	0	0	12.2
2015	7	20	21	34	8	34	0	0	0	0	0	0	0	69.55	0	0	12.2
2015	7	20	21	44	8	35	0	0	0	0	0	0	0	69.55	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	20	21	54	8	35	0	0	0	0	0	0	0	69.57	0	0	12.2
2015	7	20	22	4	8	34	0	0	0	0	0	0	0	69.58	0	0	12.2
2015	7	20	22	14	8	35	0	0	0	0	0	0	0	69.58	0	0	12.2
2015	7	20	22	24	8	35	0	0	0	0	0	0	0	69.6	0	0	12.2
2015	7	20	22	34	8	34	0	0	0	0	0	0	0	69.6	0	0	12.2
2015	7	20	22	44	8	34	0	0	0	0	0	0	0	69.6	0	0	12.2
2015	7	20	22	54	8	34	0	0	0	0	0	0	0	69.6	0	0	12.2
2015	7	20	23	4	8	35	0	0	0	0	0	0	0	69.62	0	0	12.2
2015	7	20	23	14	8	34	0	0	0	0	0	0	0	69.6	0	0	12
2015	7	20	23	24	8	35	0	0	0	0	0	0	0	69.62	0	0	12
2015	7	20	23	34	8	35	0	0	0	0	0	0	0	69.62	0	0	12
2015	7	20	23	44	8	35	0	0	0	0	0	0	0	69.62	0	0	12
2015	7	20	23	54	8	35	0	0	0	0	0	0	0	69.62	0	0	12
2015	7	21	0	4	8	34	0	0	0	0	0	0	0	69.6	0	0	12
2015	7	21	0	14	8	35	0	0	0	0	0	0	0	69.58	0	0	12
2015	7	21	0	24	8	35	0	0	0	0	0	0	0	69.57	0	0	12
2015	7	21	0	34	8	35	0	0	0	0	0	0	0	69.57	0	0	12
2015	7	21	0	44	8	35	0	0	0	0	0	0	0	69.55	0	0	12
2015	7	21	0	54	8	35	0	0	0	0	0	0	0	69.55	0	0	12
2015	7	21	1	4	8	34	0	0	0	0	0	0	0	69.53	0	0	12
2015	7	21	1	14	8	34	0	0	0	0	0	0	0	69.53	0	0	12
2015	7	21	1	24	8	34	0	0	0	0	0	0	0	69.51	0	0	12
2015	7	21	1	34	8	35	0	0	0	0	0	0	0	69.49	0	0	12
2015	7	21	1	44	8	35	0	0	0	0	0	0	0	69.48	0	0	12
2015	7	21	1	54	8	34	0	0	0	0	0	0	0	69.46	0	0	12
2015	7	21	2	4	8	34	0	0	0	0	0	0	0	69.44	0	0	12
2015	7	21	2	14	8	34	0	0	0	0	0	0	0	69.44	0	0	12
2015	7	21	2	24	8	34	0	0	0	0	0	0	0	69.42	0	0	12
2015	7	21	2	34	8	34	0	0	0	0	0	0	0	69.4	0	0	12
2015	7	21	2	44	8	34	0	0	0	0	0	0	0	69.39	0	0	12
2015	7	21	2	54	8	35	0	0	0	0	0	0	0	69.37	0	0	12
2015	7	21	3	4	8	34	0	0	0	0	0	0	0	69.35	0	0	12
2015	7	21	3	14	8	34	0	0	0	0	0	0	0	69.31	0	0	12
2015	7	21	3	24	8	35	0	0	0	0	0	0	0	69.3	0	0	12
2015	7	21	3	34	8	34	0	0	0	0	0	0	0	69.28	0	0	12
2015	7	21	3	44	8	34	0	0	0	0	0	0	0	69.24	0	0	12
2015	7	21	3	54	8	34	0	0	0	0	0	0	0	69.24	0	0	12
2015	7	21	4	4	8	34	0	0	0	0	0	0	0	69.22	0	0	12
2015	7	21	4	14	8	35	0	0	0	0	0	0	0	69.19	0	0	12
2015	7	21	4	24	8	35	0	0	0	0	0	0	0	69.15	0	0	12
2015	7	21	4	34	8	34	0	0	0	0	0	0	0	69.12	0	0	12
2015	7	21	4	44	8	34	0	0	0	0	0	0	0	69.1	0	0	12
2015	7	21	4	54	8	34	0	0	0	0	0	0	0	69.06	0	0	12
2015	7	21	5	4	8	35	0	0	0	0	0	0	0	69.04	0	0	12
2015	7	21	5	14	8	35	0	0	0	0	0	0	0	69.01	0	0	12
2015	7	21	5	24	8	34	0	0	0	0	0	0	0	68.99	0	0	12
2015	7	21	5	34	8	34	0	0	0	0	0	0	0	68.95	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	21	5	44	8	34	0	0	0	0	0	0	0	68.92	0	0	12
2015	7	21	5	54	8	35	0	0	0	0	0	0	0	68.9	0	0	12
2015	7	21	6	4	8	35	0	0	0	0	0	0	0	68.86	0	0	12
2015	7	21	6	14	8	35	0	0	0	0	0	0	0	68.85	0	0	12
2015	7	21	6	24	8	35	0	0	0	0	0	0	0	68.83	0	0	12
2015	7	21	6	34	8	35	0	0	0	0	0	0	0	68.79	0	0	12
2015	7	21	6	44	8	34	0	0	0	0	0	0	0	68.77	0	0	12
2015	7	21	6	54	8	35	0	0	0	0	0	0	0	68.76	0	0	12
2015	7	21	7	4	8	34	0	0	0	0	0	0	0	68.74	0	0	12
2015	7	21	7	14	8	35	0	0	0	0	0	0	0	68.72	0	0	12.2
2015	7	21	7	24	8	34	0	0	0	0	0	0	0	68.74	0	0	12.2
2015	7	21	7	34	8	35	0	0	0	0	0	0	0	68.74	0	0	12.4
2015	7	21	7	44	8	35	0	0	0	0	0	0	0	68.74	0	0	12.6
2015	7	21	7	54	8	35	0	0	0	0	0	0	0	68.77	0	0	12.6
2015	7	21	8	4	8	34	0	0	0	0	0	0	0	68.77	0	0	12.6
2015	7	21	8	14	8	34	0	0	0	0	0	0	0	68.79	0	0	12.8
2015	7	21	8	24	8	34	0	0	0	0	0	0	0	68.81	0	0	12.8
2015	7	21	8	34	8	34	0	0	0	0	0	0	0	68.79	0	0	12.6
2015	7	21	8	44	8	35	0	0	0	0	0	0	0	68.83	0	0	12.8
2015	7	21	8	54	8	35	0	0	0	0	0	0	0	68.86	0	0	12.8
2015	7	21	9	4	8	35	0	0	0	0	0	0	0	68.83	0	0	12.8
2015	7	21	9	14	8	35	0	0	0	0	0	0	0	68.9	0	0	12.8
2015	7	21	9	24	8	35	0	0	0	0	0	0	0	68.97	0	0	13
2015	7	21	9	34	8	35	0	0	0	0	0	0	0	69.04	0	0	13
2015	7	21	9	44	8	35	0	0	0	0	0	0	0	69.08	0	0	13.2
2015	7	21	9	54	8	35	0	0	0	0	0	0	0	69.1	0	0	13.2
2015	7	21	10	4	8	35	0	0	0	0	0	0	0	69.13	0	0	13.2
2015	7	21	10	14	8	35	0	0	0	0	0	0	0	69.17	0	0	13.2
2015	7	21	10	24	8	35	0	0	0	0	0	0	0	69.22	0	0	13.2
2015	7	21	10	34	8	34	0	0	0	0	0	0	0	69.24	0	0	13.2
2015	7	21	10	44	8	34	0	0	0	0	0	0	0	69.28	0	0	13.2
2015	7	21	10	54	8	35	0	0	0	0	0	0	0	69.33	0	0	13.2
2015	7	21	11	4	8	34	0	0	0	0	0	0	0	69.37	0	0	13.2
2015	7	21	11	14	8	35	0	0	0	0	0	0	0	69.44	0	0	13.2
2015	7	21	11	24	8	34	0	0	0	0	0	0	0	69.48	0	0	13.2
2015	7	21	11	34	8	34	0	0	0	0	0	0	0	69.48	0	0	13.2
2015	7	21	11	44	8	35	0	0	0	0	0	0	0	69.53	0	0	13.2
2015	7	21	11	54	8	34	0	0	0	0	0	0	0	69.58	0	0	13.2
2015	7	21	12	4	8	35	0	0	0	0	0	0	0	69.62	0	0	13.2
2015	7	21	12	14	8	34	0	0	0	0	0	0	0	69.64	0	0	13.2
2015	7	21	12	24	8	35	0	0	0	0	0	0	0	69.71	0	0	13.2
2015	7	21	12	34	8	34	0	0	0	0	0	0	0	69.71	0	0	13.2
2015	7	21	12	44	8	35	0	0	0	0	0	0	0	69.75	0	0	13.2
2015	7	21	12	54	8	35	0	0	0	0	0	0	0	69.76	0	0	13.2
2015	7	21	13	4	8	35	0	0	0	0	0	0	0	69.78	0	0	13.2
2015	7	21	13	14	8	34	0	0	0	0	0	0	0	69.85	0	0	13.2
2015	7	21	13	24	8	34	0	0	0	0	0	0	0	69.87	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	21	13	34	8	35		0	0	0	0	0	0	69.89	0	0	13.2
2015	7	21	13	44	8	34		0	0	0	0	0	0	69.91	0	0	13.2
2015	7	21	13	54	8	34		0	0	0	0	0	0	69.93	0	0	13.2
2015	7	21	14	4	8	34		0	0	0	0	0	0	69.94	0	0	13.2
2015	7	21	14	14	8	35		0	0	0	0	0	0	69.96	0	0	13.2
2015	7	21	14	24	8	34		0	0	0	0	0	0	69.96	0	0	13.2
2015	7	21	14	34	8	35		0	0	0	0	0	0	70	0	0	13.2
2015	7	21	14	44	8	34		0	0	0	0	0	0	70	0	0	13.2
2015	7	21	14	54	8	35		0	0	0	0	0	0	70	0	0	13.2
2015	7	21	15	4	8	35		0	0	0	0	0	0	69.98	0	0	13.2
2015	7	21	15	14	8	34		0	0	0	0	0	0	69.98	0	0	13.2
2015	7	21	15	24	8	34		0	0	0	0	0	0	70	0	0	13.2
2015	7	21	15	34	8	34		0	0	0	0	0	0	70	0	0	13.2
2015	7	21	15	44	8	35		0	0	0	0	0	0	69.96	0	0	13.2
2015	7	21	15	54	8	35		0	0	0	0	0	0	69.87	0	0	13.2
2015	7	21	16	4	8	35		0	0	0	0	0	0	69.8	0	0	13.2
2015	7	21	16	14	8	34		0	0	0	0	0	0	69.82	0	0	13.2
2015	7	21	16	24	8	34		0	0	0	0	0	0	69.8	0	0	13.2
2015	7	21	16	34	8	34		0	0	0	0	0	0	69.78	0	0	13
2015	7	21	16	44	8	35		0	0	0	0	0	0	69.78	0	0	13.2
2015	7	21	16	54	8	35		0	0	0	0	0	0	69.76	0	0	13.2
2015	7	21	17	4	8	34		0	0	0	0	0	0	69.78	0	0	13.2
2015	7	21	17	14	8	35		0	0	0	0	0	0	69.78	0	0	13.2
2015	7	21	17	24	8	35		0	0	0	0	0	0	69.8	0	0	13.2
2015	7	21	17	34	8	34		0	0	0	0	0	0	69.8	0	0	12.8
2015	7	21	17	44	8	34		0	0	0	0	0	0	69.82	0	0	13.4
2015	7	21	17	54	8	35		0	0	0	0	0	0	69.82	0	0	13.4
2015	7	21	18	4	8	35		0	0	0	0	0	0	69.84	0	0	12.4
2015	7	21	18	14	8	34		0	0	0	0	0	0	69.84	0	0	12.2
2015	7	21	18	24	8	35		0	0	0	0	0	0	69.85	0	0	12.2
2015	7	21	18	34	8	34		0	0	0	0	0	0	69.87	0	0	12.2
2015	7	21	18	44	8	35		0	0	0	0	0	0	69.89	0	0	12.2
2015	7	21	18	54	8	35		0	0	0	0	0	0	69.91	0	0	12.2
2015	7	21	19	4	8	35		0	0	0	0	0	0	69.94	0	0	12.2
2015	7	21	19	14	8	34		0	0	0	0	0	0	69.94	0	0	12.2
2015	7	21	19	24	8	34		0	0	0	0	0	0	69.96	0	0	12.2
2015	7	21	19	34	8	34		0	0	0	0	0	0	70	0	0	12.2
2015	7	21	19	44	8	33		0	0	0	0	0	0	70.02	0	0	12.2
2015	7	21	19	54	8	34		0	0	0	0	0	0	70.05	0	0	12.2
2015	7	21	20	4	8	34		0	0	0	0	0	0	70.07	0	0	12.2
2015	7	21	20	14	8	34		0	0	0	0	0	0	70.09	0	0	12.2
2015	7	21	20	24	8	34		0	0	0	0	0	0	70.11	0	0	12.2
2015	7	21	20	34	8	34		0	0	0	0	0	0	70.14	0	0	12.2
2015	7	21	20	44	8	35		0	0	0	0	0	0	70.16	0	0	12.2
2015	7	21	20	54	8	34		0	0	0	0	0	0	70.18	0	0	12.2
2015	7	21	21	4	8	35		0	0	0	0	0	0	70.21	0	0	12.2
2015	7	21	21	14	8	34		0	0	0	0	0	0	70.25	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	21	21	24	8	34		0	0	0	0	0	0	70.29	0	0	12.2
2015	7	21	21	34	8	35		0	0	0	0	0	0	70.3	0	0	12
2015	7	21	21	44	8	35		0	0	0	0	0	0	70.32	0	0	12.2
2015	7	21	21	54	8	35		0	0	0	0	0	0	70.34	0	0	12.2
2015	7	21	22	4	8	34		0	0	0	0	0	0	70.36	0	0	12.2
2015	7	21	22	14	8	34		0	0	0	0	0	0	70.38	0	0	12.2
2015	7	21	22	24	8	34		0	0	0	0	0	0	70.41	0	0	12.2
2015	7	21	22	34	8	34		0	0	0	0	0	0	70.43	0	0	12
2015	7	21	22	44	8	34		0	0	0	0	0	0	70.43	0	0	12.2
2015	7	21	22	54	8	35		0	0	0	0	0	0	70.45	0	0	12
2015	7	21	23	4	8	34		0	0	0	0	0	0	70.45	0	0	12
2015	7	21	23	14	8	34		0	0	0	0	0	0	70.47	0	0	12
2015	7	21	23	24	8	35		0	0	0	0	0	0	70.45	0	0	12
2015	7	21	23	34	8	34		0	0	0	0	0	0	70.45	0	0	12
2015	7	21	23	44	8	34		0	0	0	0	0	0	70.45	0	0	12
2015	7	21	23	54	8	34		0	0	0	0	0	0	70.45	0	0	12
2015	7	22	0	4	8	34		0	0	0	0	0	0	70.45	0	0	12
2015	7	22	0	14	8	34		0	0	0	0	0	0	70.43	0	0	12
2015	7	22	0	24	8	34		0	0	0	0	0	0	70.43	0	0	12
2015	7	22	0	34	8	34		0	0	0	0	0	0	70.41	0	0	12
2015	7	22	0	44	8	34		0	0	0	0	0	0	70.39	0	0	12
2015	7	22	0	54	8	35		0	0	0	0	0	0	70.38	0	0	12
2015	7	22	1	4	8	34		0	0	0	0	0	0	70.36	0	0	12
2015	7	22	1	14	8	35		0	0	0	0	0	0	70.32	0	0	12
2015	7	22	1	24	8	34		0	0	0	0	0	0	70.3	0	0	12
2015	7	22	1	34	8	34		0	0	0	0	0	0	70.29	0	0	12
2015	7	22	1	44	8	34		0	0	0	0	0	0	70.25	0	0	12
2015	7	22	1	54	8	34		0	0	0	0	0	0	70.23	0	0	12
2015	7	22	2	4	8	35		0	0	0	0	0	0	70.2	0	0	12
2015	7	22	2	14	8	34		0	0	0	0	0	0	70.16	0	0	12
2015	7	22	2	24	8	35		0	0	0	0	0	0	70.14	0	0	12
2015	7	22	2	34	8	34		0	0	0	0	0	0	70.11	0	0	12
2015	7	22	2	44	8	34		0	0	0	0	0	0	70.09	0	0	12
2015	7	22	2	54	8	34		0	0	0	0	0	0	70.03	0	0	12
2015	7	22	3	4	8	34		0	0	0	0	0	0	70	0	0	12
2015	7	22	3	14	8	35		0	0	0	0	0	0	69.96	0	0	12
2015	7	22	3	24	8	35		0	0	0	0	0	0	69.93	0	0	12
2015	7	22	3	34	8	34		0	0	0	0	0	0	69.89	0	0	12
2015	7	22	3	44	8	34		0	0	0	0	0	0	69.85	0	0	12
2015	7	22	3	54	8	35		0	0	0	0	0	0	69.82	0	0	12
2015	7	22	4	4	8	35		0	0	0	0	0	0	69.78	0	0	12
2015	7	22	4	14	8	35		0	0	0	0	0	0	69.76	0	0	12
2015	7	22	4	24	8	35		0	0	0	0	0	0	69.71	0	0	12
2015	7	22	4	34	8	34		0	0	0	0	0	0	69.67	0	0	12
2015	7	22	4	44	8	34		0	0	0	0	0	0	69.64	0	0	12
2015	7	22	4	54	8	35		0	0	0	0	0	0	69.6	0	0	12
2015	7	22	5	4	8	34		0	0	0	0	0	0	69.57	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	22	5	14	8	34		0	0	0	0	0	0	69.53	0	0	12
2015	7	22	5	24	8	35		0	0	0	0	0	0	69.49	0	0	12
2015	7	22	5	34	8	35		0	0	0	0	0	0	69.46	0	0	11.8
2015	7	22	5	44	8	35		0	0	0	0	0	0	69.42	0	0	12
2015	7	22	5	54	8	35		0	0	0	0	0	0	69.39	0	0	12
2015	7	22	6	4	8	34		0	0	0	0	0	0	69.35	0	0	12
2015	7	22	6	14	8	34		0	0	0	0	0	0	69.31	0	0	12
2015	7	22	6	24	8	34		0	0	0	0	0	0	69.26	0	0	12
2015	7	22	6	34	8	35		0	0	0	0	0	0	69.22	0	0	12
2015	7	22	6	44	8	34		0	0	0	0	0	0	69.21	0	0	12
2015	7	22	6	54	8	35		0	0	0	0	0	0	69.17	0	0	12
2015	7	22	7	4	8	34		0	0	0	0	0	0	69.15	0	0	12.2
2015	7	22	7	14	8	35		0	0	0	0	0	0	69.12	0	0	12.2
2015	7	22	7	24	8	34		0	0	0	0	0	0	69.12	0	0	12.2
2015	7	22	7	34	8	34		0	0	0	0	0	0	69.12	0	0	12.4
2015	7	22	7	44	8	35		0	0	0	0	0	0	69.12	0	0	12.4
2015	7	22	7	54	8	35		0	0	0	0	0	0	69.1	0	0	12.6
2015	7	22	8	4	8	34		0	0	0	0	0	0	69.12	0	0	12.6
2015	7	22	8	14	8	34		0	0	0	0	0	0	69.12	0	0	12.8
2015	7	22	8	24	8	35		0	0	0	0	0	0	69.12	0	0	12.8
2015	7	22	8	34	8	35		0	0	0	0	0	0	69.12	0	0	12.8
2015	7	22	8	44	8	34		0	0	0	0	0	0	69.15	0	0	12.8
2015	7	22	8	54	8	34		0	0	0	0	0	0	69.17	0	0	12.8
2015	7	22	9	4	8	34		0	0	0	0	0	0	69.19	0	0	13
2015	7	22	9	14	8	35		0	0	0	0	0	0	69.21	0	0	13
2015	7	22	9	24	8	35		0	0	0	0	0	0	69.22	0	0	13
2015	7	22	9	34	8	35		0	0	0	0	0	0	69.26	0	0	13.2
2015	7	22	9	44	8	35		0	0	0	0	0	0	69.28	0	0	13.2
2015	7	22	9	54	8	35		0	0	0	0	0	0	69.31	0	0	13.2
2015	7	22	10	4	8	35		0	0	0	0	0	0	69.35	0	0	13.2
2015	7	22	10	14	8	35		0	0	0	0	0	0	69.37	0	0	13.2
2015	7	22	10	24	8	35		0	0	0	0	0	0	69.4	0	0	13.2
2015	7	22	10	34	8	35		0	0	0	0	0	0	69.42	0	0	13.2
2015	7	22	10	44	8	35		0	0	0	0	0	0	69.48	0	0	13.2
2015	7	22	10	54	8	35		0	0	0	0	0	0	69.51	0	0	13.2
2015	7	22	11	4	8	35		0	0	0	0	0	0	69.53	0	0	13.2
2015	7	22	11	14	8	34		0	0	0	0	0	0	69.58	0	0	13.2
2015	7	22	11	24	8	35		0	0	0	0	0	0	69.6	0	0	13.2
2015	7	22	11	34	8	35		0	0	0	0	0	0	69.62	0	0	13.2
2015	7	22	11	44	8	35		0	0	0	0	0	0	69.64	0	0	13.2
2015	7	22	11	54	8	36		0	0	0	0	0	0	69.67	0	0	13.2
2015	7	22	12	4	8	35		0	0	0	0	0	0	69.71	0	0	13.2
2015	7	22	12	14	8	33		0	0	0	0	0	0	69.73	0	0	13.2
2015	7	22	12	24	8	35		0	0	0	0	0	0	69.75	0	0	13.2
2015	7	22	12	34	8	35		0	0	0	0	0	0	69.78	0	0	13.2
2015	7	22	12	44	8	34		0	0	0	0	0	0	69.82	0	0	13.2
2015	7	22	12	54	8	34		0	0	0	0	0	0	69.82	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	22	13	4	8	34	0	0	0	0	0	0	0	69.84	0	0	13.2
2015	7	22	13	14	8	34	0	0	0	0	0	0	0	69.87	0	0	13.2
2015	7	22	13	24	8	34	0	0	0	0	0	0	0	69.89	0	0	13.2
2015	7	22	13	34	8	35	0	0	0	0	0	0	0	69.89	0	0	13.2
2015	7	22	13	44	8	35	0	0	0	0	0	0	0	69.91	0	0	13.2
2015	7	22	13	54	8	35	0	0	0	0	0	0	0	69.93	0	0	13.2
2015	7	22	14	4	8	35	0	0	0	0	0	0	0	69.91	0	0	13.2
2015	7	22	14	14	8	34	0	0	0	0	0	0	0	69.94	0	0	13.2
2015	7	22	14	24	8	34	0	0	0	0	0	0	0	69.93	0	0	13.2
2015	7	22	14	34	8	35	0	0	0	0	0	0	0	69.93	0	0	13.2
2015	7	22	14	44	8	34	0	0	0	0	0	0	0	69.93	0	0	13.2
2015	7	22	14	54	8	34	0	0	0	0	0	0	0	69.93	0	0	13.2
2015	7	22	15	4	8	34	0	0	0	0	0	0	0	69.91	0	0	13.2
2015	7	22	15	14	8	34	0	0	0	0	0	0	0	69.91	0	0	13.2
2015	7	22	15	24	8	34	0	0	0	0	0	0	0	69.91	0	0	13.2
2015	7	22	15	34	8	34	0	0	0	0	0	0	0	69.87	0	0	13.2
2015	7	22	15	44	8	34	0	0	0	0	0	0	0	69.85	0	0	13.2
2015	7	22	15	54	8	35	0	0	0	0	0	0	0	69.87	0	0	13.2
2015	7	22	16	4	8	34	0	0	0	0	0	0	0	69.8	0	0	13.2
2015	7	22	16	14	8	34	0	0	0	0	0	0	0	69.76	0	0	13.2
2015	7	22	16	24	8	35	0	0	0	0	0	0	0	69.71	0	0	13.2
2015	7	22	16	34	8	35	0	0	0	0	0	0	0	69.69	0	0	13.2
2015	7	22	16	44	8	35	0	0	0	0	0	0	0	69.69	0	0	13.2
2015	7	22	16	54	8	35	0	0	0	0	0	0	0	69.69	0	0	13.4
2015	7	22	17	4	8	34	0	0	0	0	0	0	0	69.69	0	0	13.4
2015	7	22	17	14	8	35	0	0	0	0	0	0	0	69.73	0	0	13.4
2015	7	22	17	24	8	35	0	0	0	0	0	0	0	69.69	0	0	13.4
2015	7	22	17	34	8	34	0	0	0	0	0	0	0	69.69	0	0	13.2
2015	7	22	17	44	8	35	0	0	0	0	0	0	0	69.71	0	0	13.4
2015	7	22	17	54	8	35	0	0	0	0	0	0	0	69.71	0	0	12.6
2015	7	22	18	4	8	34	0	0	0	0	0	0	0	69.71	0	0	12.4
2015	7	22	18	14	8	34	0	0	0	0	0	0	0	69.73	0	0	12.4
2015	7	22	18	24	8	35	0	0	0	0	0	0	0	69.73	0	0	12.2
2015	7	22	18	34	8	34	0	0	0	0	0	0	0	69.75	0	0	12.2
2015	7	22	18	44	8	34	0	0	0	0	0	0	0	69.76	0	0	12.2
2015	7	22	18	54	8	34	0	0	0	0	0	0	0	69.76	0	0	12.2
2015	7	22	19	4	8	34	0	0	0	0	0	0	0	69.8	0	0	12.2
2015	7	22	19	14	8	35	0	0	0	0	0	0	0	69.82	0	0	12.2
2015	7	22	19	24	8	34	0	0	0	0	0	0	0	69.84	0	0	12.2
2015	7	22	19	34	8	34	0	0	0	0	0	0	0	69.85	0	0	12.2
2015	7	22	19	44	8	34	0	0	0	0	0	0	0	69.87	0	0	12.2
2015	7	22	19	54	8	34	0	0	0	0	0	0	0	69.89	0	0	12.2
2015	7	22	20	4	8	34	0	0	0	0	0	0	0	69.93	0	0	12.2
2015	7	22	20	14	8	34	0	0	0	0	0	0	0	69.96	0	0	12.2
2015	7	22	20	24	8	35	0	0	0	0	0	0	0	69.98	0	0	12.2
2015	7	22	20	34	8	34	0	0	0	0	0	0	0	70.02	0	0	12.2
2015	7	22	20	44	8	34	0	0	0	0	0	0	0	70.03	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	22	20	54	8	34		0	0	0	0	0	0	70.07	0	0	12.2
2015	7	22	21	4	8	35		0	0	0	0	0	0	70.09	0	0	12.2
2015	7	22	21	14	8	34		0	0	0	0	0	0	70.12	0	0	12.2
2015	7	22	21	24	8	34		0	0	0	0	0	0	70.14	0	0	12.2
2015	7	22	21	34	8	34		0	0	0	0	0	0	70.18	0	0	12.2
2015	7	22	21	44	8	35		0	0	0	0	0	0	70.21	0	0	12.2
2015	7	22	21	54	8	34		0	0	0	0	0	0	70.23	0	0	12.2
2015	7	22	22	4	8	35		0	0	0	0	0	0	70.27	0	0	12.2
2015	7	22	22	14	8	34		0	0	0	0	0	0	70.29	0	0	12.2
2015	7	22	22	24	8	35		0	0	0	0	0	0	70.3	0	0	12.2
2015	7	22	22	34	8	34		0	0	0	0	0	0	70.34	0	0	12
2015	7	22	22	44	8	35		0	0	0	0	0	0	70.36	0	0	12.2
2015	7	22	22	54	8	34		0	0	0	0	0	0	70.38	0	0	12.2
2015	7	22	23	4	8	35		0	0	0	0	0	0	70.38	0	0	12.2
2015	7	22	23	14	8	35		0	0	0	0	0	0	70.39	0	0	12.2
2015	7	22	23	24	8	34		0	0	0	0	0	0	70.39	0	0	12.2
2015	7	22	23	34	8	34		0	0	0	0	0	0	70.39	0	0	12
2015	7	22	23	44	8	34		0	0	0	0	0	0	70.41	0	0	12
2015	7	22	23	54	8	34		0	0	0	0	0	0	70.41	0	0	12
2015	7	23	0	4	8	34		0	0	0	0	0	0	70.41	0	0	12
2015	7	23	0	14	8	35		0	0	0	0	0	0	70.41	0	0	12
2015	7	23	0	24	8	34		0	0	0	0	0	0	70.39	0	0	12
2015	7	23	0	34	8	35		0	0	0	0	0	0	70.39	0	0	12
2015	7	23	0	44	8	35		0	0	0	0	0	0	70.38	0	0	12
2015	7	23	0	54	8	34		0	0	0	0	0	0	70.38	0	0	12
2015	7	23	1	4	8	35		0	0	0	0	0	0	70.36	0	0	12
2015	7	23	1	14	8	34		0	0	0	0	0	0	70.34	0	0	12
2015	7	23	1	24	8	34		0	0	0	0	0	0	70.32	0	0	12
2015	7	23	1	34	8	34		0	0	0	0	0	0	70.3	0	0	12
2015	7	23	1	44	8	34		0	0	0	0	0	0	70.29	0	0	12
2015	7	23	1	54	8	34		0	0	0	0	0	0	70.27	0	0	12
2015	7	23	2	4	8	35		0	0	0	0	0	0	70.23	0	0	12
2015	7	23	2	14	8	35		0	0	0	0	0	0	70.2	0	0	12
2015	7	23	2	24	8	35		0	0	0	0	0	0	70.18	0	0	12
2015	7	23	2	34	8	35		0	0	0	0	0	0	70.16	0	0	12
2015	7	23	2	44	8	34		0	0	0	0	0	0	70.14	0	0	12
2015	7	23	2	54	8	35		0	0	0	0	0	0	70.09	0	0	12
2015	7	23	3	4	8	34		0	0	0	0	0	0	70.05	0	0	12
2015	7	23	3	14	8	34		0	0	0	0	0	0	70.03	0	0	12
2015	7	23	3	24	8	34		0	0	0	0	0	0	70	0	0	12
2015	7	23	3	34	8	34		0	0	0	0	0	0	69.96	0	0	12
2015	7	23	3	44	8	35		0	0	0	0	0	0	69.93	0	0	12
2015	7	23	3	54	8	35		0	0	0	0	0	0	69.87	0	0	12
2015	7	23	4	4	8	35		0	0	0	0	0	0	69.84	0	0	12
2015	7	23	4	14	8	34		0	0	0	0	0	0	69.8	0	0	12
2015	7	23	4	24	8	35		0	0	0	0	0	0	69.78	0	0	12
2015	7	23	4	34	8	34		0	0	0	0	0	0	69.73	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	23	4	44	8	34		0	0	0	0	0	0	69.71	0	0	12
2015	7	23	4	54	8	34		0	0	0	0	0	0	69.67	0	0	12
2015	7	23	5	4	8	35		0	0	0	0	0	0	69.64	0	0	12
2015	7	23	5	14	8	34		0	0	0	0	0	0	69.6	0	0	12
2015	7	23	5	24	8	35		0	0	0	0	0	0	69.57	0	0	12
2015	7	23	5	34	8	34		0	0	0	0	0	0	69.53	0	0	12
2015	7	23	5	44	8	35		0	0	0	0	0	0	69.49	0	0	12
2015	7	23	5	54	8	35		0	0	0	0	0	0	69.46	0	0	12
2015	7	23	6	4	8	34		0	0	0	0	0	0	69.44	0	0	12
2015	7	23	6	14	8	34		0	0	0	0	0	0	69.4	0	0	12
2015	7	23	6	24	8	34		0	0	0	0	0	0	69.39	0	0	12
2015	7	23	6	34	8	34		0	0	0	0	0	0	69.35	0	0	12
2015	7	23	6	44	8	35		0	0	0	0	0	0	69.31	0	0	12
2015	7	23	6	54	8	34		0	0	0	0	0	0	69.3	0	0	12
2015	7	23	7	4	8	34		0	0	0	0	0	0	69.26	0	0	12.2
2015	7	23	7	14	8	34		0	0	0	0	0	0	69.24	0	0	12.2
2015	7	23	7	24	8	34		0	0	0	0	0	0	69.24	0	0	12.2
2015	7	23	7	34	8	35		0	0	0	0	0	0	69.24	0	0	12.4
2015	7	23	7	44	8	34		0	0	0	0	0	0	69.24	0	0	12.4
2015	7	23	7	54	8	35		0	0	0	0	0	0	69.26	0	0	12.6
2015	7	23	8	4	8	35		0	0	0	0	0	0	69.26	0	0	12.6
2015	7	23	8	14	8	35		0	0	0	0	0	0	69.26	0	0	12.6
2015	7	23	8	24	8	35		0	0	0	0	0	0	69.3	0	0	12.8
2015	7	23	8	34	8	35		0	0	0	0	0	0	69.3	0	0	12.8
2015	7	23	8	44	8	35		0	0	0	0	0	0	69.31	0	0	12.8
2015	7	23	8	54	8	34		0	0	0	0	0	0	69.33	0	0	12.8
2015	7	23	9	4	8	35		0	0	0	0	0	0	69.35	0	0	13
2015	7	23	9	14	8	35		0	0	0	0	0	0	69.39	0	0	13
2015	7	23	9	24	8	35		0	0	0	0	0	0	69.4	0	0	13
2015	7	23	9	34	8	35		0	0	0	0	0	0	69.42	0	0	13.2
2015	7	23	9	44	8	34		0	0	0	0	0	0	69.46	0	0	13.2
2015	7	23	9	54	8	34		0	0	0	0	0	0	69.49	0	0	13.2
2015	7	23	10	4	8	34		0	0	0	0	0	0	69.53	0	0	13.2
2015	7	23	10	14	8	34		0	0	0	0	0	0	69.55	0	0	13.2
2015	7	23	10	24	8	34		0	0	0	0	0	0	69.6	0	0	13.2
2015	7	23	10	34	8	35		0	0	0	0	0	0	69.62	0	0	13.2
2015	7	23	10	44	8	34		0	0	0	0	0	0	69.64	0	0	13.2
2015	7	23	10	54	8	35		0	0	0	0	0	0	69.67	0	0	13.2
2015	7	23	11	4	8	35		0	0	0	0	0	0	69.71	0	0	13.2
2015	7	23	11	14	8	34		0	0	0	0	0	0	69.75	0	0	13.2
2015	7	23	11	24	8	36		0	0	0	0	0	0	69.76	0	0	13.2
2015	7	23	11	34	8	34		0	0	0	0	0	0	69.8	0	0	13.2
2015	7	23	11	44	8	34		0	0	0	0	0	0	69.85	0	0	13.2
2015	7	23	11	54	8	35		0	0	0	0	0	0	69.87	0	0	13.2
2015	7	23	12	4	8	34		0	0	0	0	0	0	69.93	0	0	13.2
2015	7	23	12	14	8	34		0	0	0	0	0	0	69.93	0	0	13.2
2015	7	23	12	24	8	35		0	0	0	0	0	0	69.96	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	23	12	34	8	35		0	0	0	0	0	0	70	0	0	13.2
2015	7	23	12	44	8	34		0	0	0	0	0	0	70.03	0	0	13.2
2015	7	23	12	54	8	34		0	0	0	0	0	0	70.07	0	0	13.2
2015	7	23	13	4	8	34		0	0	0	0	0	0	70.11	0	0	13.2
2015	7	23	13	14	8	34		0	0	0	0	0	0	70.12	0	0	13.2
2015	7	23	13	24	8	35		0	0	0	0	0	0	70.14	0	0	13.2
2015	7	23	13	34	8	35		0	0	0	0	0	0	70.14	0	0	13.2
2015	7	23	13	44	8	34		0	0	0	0	0	0	70.16	0	0	13.2
2015	7	23	13	54	8	35		0	0	0	0	0	0	70.16	0	0	13.2
2015	7	23	14	4	8	35		0	0	0	0	0	0	70.18	0	0	13.2
2015	7	23	14	14	8	34		0	0	0	0	0	0	70.16	0	0	13.2
2015	7	23	14	24	8	34		0	0	0	0	0	0	70.16	0	0	13.2
2015	7	23	14	34	8	35		0	0	0	0	0	0	70.18	0	0	13.2
2015	7	23	14	44	8	35		0	0	0	0	0	0	70.18	0	0	13.2
2015	7	23	14	54	8	34		0	0	0	0	0	0	70.18	0	0	13.2
2015	7	23	15	4	8	34		0	0	0	0	0	0	70.16	0	0	13.2
2015	7	23	15	14	8	34		0	0	0	0	0	0	70.14	0	0	13.2
2015	7	23	15	24	8	35		0	0	0	0	0	0	70.12	0	0	13.2
2015	7	23	15	34	8	35		0	0	0	0	0	0	70.12	0	0	13.2
2015	7	23	15	44	8	35		0	0	0	0	0	0	70.09	0	0	13.2
2015	7	23	15	54	8	35		0	0	0	0	0	0	70.11	0	0	13.2
2015	7	23	16	4	8	34		0	0	0	0	0	0	70.07	0	0	13.2
2015	7	23	16	14	8	34		0	0	0	0	0	0	70.05	0	0	13.2
2015	7	23	16	24	8	35		0	0	0	0	0	0	70.03	0	0	13.2
2015	7	23	16	34	8	35		0	0	0	0	0	0	70.03	0	0	13.2
2015	7	23	16	44	8	34		0	0	0	0	0	0	70.02	0	0	13.2
2015	7	23	16	54	8	34		0	0	0	0	0	0	70	0	0	13.2
2015	7	23	17	4	8	34		0	0	0	0	0	0	70	0	0	13.2
2015	7	23	17	14	8	34		0	0	0	0	0	0	69.98	0	0	13.2
2015	7	23	17	24	8	34		0	0	0	0	0	0	69.96	0	0	13.2
2015	7	23	17	34	8	34		0	0	0	0	0	0	69.94	0	0	13
2015	7	23	17	44	8	34		0	0	0	0	0	0	69.93	0	0	13.2
2015	7	23	17	54	8	34		0	0	0	0	0	0	69.91	0	0	13.2
2015	7	23	18	4	8	34		0	0	0	0	0	0	69.91	0	0	13.2
2015	7	23	18	14	8	34		0	0	0	0	0	0	69.91	0	0	13.2
2015	7	23	18	24	8	35		0	0	0	0	0	0	69.91	0	0	13.2
2015	7	23	18	34	8	34		0	0	0	0	0	0	69.93	0	0	12.4
2015	7	23	18	44	8	34		0	0	0	0	0	0	69.94	0	0	12.2
2015	7	23	18	54	8	34		0	0	0	0	0	0	69.94	0	0	12.2
2015	7	23	19	4	8	34		0	0	0	0	0	0	69.94	0	0	12.2
2015	7	23	19	14	8	35		0	0	0	0	0	0	69.96	0	0	12.2
2015	7	23	19	24	8	34		0	0	0	0	0	0	69.96	0	0	12.2
2015	7	23	19	34	8	35		0	0	0	0	0	0	69.98	0	0	12.2
2015	7	23	19	44	8	34		0	0	0	0	0	0	70	0	0	12.2
2015	7	23	19	54	8	35		0	0	0	0	0	0	70.02	0	0	12.2
2015	7	23	20	4	8	35		0	0	0	0	0	0	70.03	0	0	12.2
2015	7	23	20	14	8	34		0	0	0	0	0	0	70.05	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	23	20	24	8	35	0	0	0	0	0	0	0	70.07	0	0	12.2
2015	7	23	20	34	8	35	0	0	0	0	0	0	0	70.09	0	0	12.2
2015	7	23	20	44	8	34	0	0	0	0	0	0	0	70.11	0	0	12.2
2015	7	23	20	54	8	34	0	0	0	0	0	0	0	70.14	0	0	12.2
2015	7	23	21	4	8	35	0	0	0	0	0	0	0	70.14	0	0	12.2
2015	7	23	21	14	8	34	0	0	0	0	0	0	0	70.16	0	0	12.2
2015	7	23	21	24	8	34	0	0	0	0	0	0	0	70.18	0	0	12.2
2015	7	23	21	34	8	34	0	0	0	0	0	0	0	70.21	0	0	12.2
2015	7	23	21	44	8	34	0	0	0	0	0	0	0	70.23	0	0	12.2
2015	7	23	21	54	8	34	0	0	0	0	0	0	0	70.25	0	0	12.2
2015	7	23	22	4	8	34	0	0	0	0	0	0	0	70.27	0	0	12.2
2015	7	23	22	14	8	34	0	0	0	0	0	0	0	70.29	0	0	12.2
2015	7	23	22	24	8	34	0	0	0	0	0	0	0	70.32	0	0	12.2
2015	7	23	22	34	8	34	0	0	0	0	0	0	0	70.34	0	0	12.2
2015	7	23	22	44	8	34	0	0	0	0	0	0	0	70.34	0	0	12.2
2015	7	23	22	54	8	34	0	0	0	0	0	0	0	70.36	0	0	12.2
2015	7	23	23	4	8	35	0	0	0	0	0	0	0	70.39	0	0	12.2
2015	7	23	23	14	8	34	0	0	0	0	0	0	0	70.39	0	0	12.2
2015	7	23	23	24	8	35	0	0	0	0	0	0	0	70.41	0	0	12.2
2015	7	23	23	34	8	35	0	0	0	0	0	0	0	70.43	0	0	12
2015	7	23	23	44	8	34	0	0	0	0	0	0	0	70.43	0	0	12
2015	7	23	23	54	8	35	0	0	0	0	0	0	0	70.43	0	0	12
2015	7	24	0	4	8	35	0	0	0	0	0	0	0	70.43	0	0	12
2015	7	24	0	14	8	34	0	0	0	0	0	0	0	70.41	0	0	12
2015	7	24	0	24	8	34	0	0	0	0	0	0	0	70.41	0	0	12
2015	7	24	0	34	8	34	0	0	0	0	0	0	0	70.39	0	0	12
2015	7	24	0	44	8	34	0	0	0	0	0	0	0	70.38	0	0	12
2015	7	24	0	54	8	35	0	0	0	0	0	0	0	70.38	0	0	12
2015	7	24	1	4	8	34	0	0	0	0	0	0	0	70.36	0	0	12
2015	7	24	1	14	8	34	0	0	0	0	0	0	0	70.32	0	0	12
2015	7	24	1	24	8	35	0	0	0	0	0	0	0	70.3	0	0	12
2015	7	24	1	34	8	34	0	0	0	0	0	0	0	70.29	0	0	12
2015	7	24	1	44	8	34	0	0	0	0	0	0	0	70.27	0	0	12
2015	7	24	1	54	8	35	0	0	0	0	0	0	0	70.23	0	0	12
2015	7	24	2	4	8	34	0	0	0	0	0	0	0	70.2	0	0	12
2015	7	24	2	14	8	34	0	0	0	0	0	0	0	70.18	0	0	12
2015	7	24	2	24	8	34	0	0	0	0	0	0	0	70.12	0	0	12
2015	7	24	2	34	8	35	0	0	0	0	0	0	0	70.11	0	0	12
2015	7	24	2	44	8	34	0	0	0	0	0	0	0	70.07	0	0	12
2015	7	24	2	54	8	34	0	0	0	0	0	0	0	70.02	0	0	12
2015	7	24	3	4	8	35	0	0	0	0	0	0	0	70	0	0	12
2015	7	24	3	14	8	35	0	0	0	0	0	0	0	69.94	0	0	12
2015	7	24	3	24	8	34	0	0	0	0	0	0	0	69.93	0	0	12
2015	7	24	3	34	8	35	0	0	0	0	0	0	0	69.87	0	0	12
2015	7	24	3	44	8	34	0	0	0	0	0	0	0	69.84	0	0	12
2015	7	24	3	54	8	34	0	0	0	0	0	0	0	69.8	0	0	12
2015	7	24	4	4	8	34	0	0	0	0	0	0	0	69.76	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	24	4	14	8	34	0	0	0	0	0	0	0	69.71	0	0	12
2015	7	24	4	24	8	34	0	0	0	0	0	0	0	69.67	0	0	12
2015	7	24	4	34	8	34	0	0	0	0	0	0	0	69.64	0	0	12
2015	7	24	4	44	8	34	0	0	0	0	0	0	0	69.58	0	0	12
2015	7	24	4	54	8	35	0	0	0	0	0	0	0	69.53	0	0	12
2015	7	24	5	4	8	34	0	0	0	0	0	0	0	69.49	0	0	12
2015	7	24	5	14	8	34	0	0	0	0	0	0	0	69.44	0	0	12
2015	7	24	5	24	8	35	0	0	0	0	0	0	0	69.4	0	0	12
2015	7	24	5	34	8	35	0	0	0	0	0	0	0	69.35	0	0	12
2015	7	24	5	44	8	34	0	0	0	0	0	0	0	69.31	0	0	12
2015	7	24	5	54	8	35	0	0	0	0	0	0	0	69.28	0	0	12
2015	7	24	6	4	8	35	0	0	0	0	0	0	0	69.24	0	0	12
2015	7	24	6	14	8	34	0	0	0	0	0	0	0	69.21	0	0	12
2015	7	24	6	24	8	35	0	0	0	0	0	0	0	69.15	0	0	12
2015	7	24	6	34	8	35	0	0	0	0	0	0	0	69.12	0	0	12
2015	7	24	6	44	8	34	0	0	0	0	0	0	0	69.08	0	0	12
2015	7	24	6	54	8	34	0	0	0	0	0	0	0	69.04	0	0	12
2015	7	24	7	4	8	35	0	0	0	0	0	0	0	69.03	0	0	12.2
2015	7	24	7	14	8	35	0	0	0	0	0	0	0	69.01	0	0	12.2
2015	7	24	7	24	8	35	0	0	0	0	0	0	0	68.99	0	0	12.2
2015	7	24	7	34	8	35	0	0	0	0	0	0	0	68.97	0	0	12.4
2015	7	24	7	44	8	34	0	0	0	0	0	0	0	68.99	0	0	12.4
2015	7	24	7	54	8	35	0	0	0	0	0	0	0	68.99	0	0	12.6
2015	7	24	8	4	8	34	0	0	0	0	0	0	0	68.97	0	0	12.6
2015	7	24	8	14	8	34	0	0	0	0	0	0	0	68.99	0	0	12.8
2015	7	24	8	24	8	34	0	0	0	0	0	0	0	69.01	0	0	12.8
2015	7	24	8	34	8	35	0	0	0	0	0	0	0	69.01	0	0	12.8
2015	7	24	8	44	8	35	0	0	0	0	0	0	0	69.03	0	0	12.8
2015	7	24	8	54	8	35	0	0	0	0	0	0	0	69.06	0	0	12.8
2015	7	24	9	4	8	35	0	0	0	0	0	0	0	69.06	0	0	13
2015	7	24	9	14	8	35	0	0	0	0	0	0	0	69.1	0	0	13
2015	7	24	9	24	8	34	0	0	0	0	0	0	0	69.13	0	0	13
2015	7	24	9	34	8	35	0	0	0	0	0	0	0	69.15	0	0	13.2
2015	7	24	9	44	8	35	0	0	0	0	0	0	0	69.19	0	0	13.2
2015	7	24	9	54	8	35	0	0	0	0	0	0	0	69.22	0	0	13.2
2015	7	24	10	4	8	35	0	0	0	0	0	0	0	69.24	0	0	13.2
2015	7	24	10	14	8	34	0	0	0	0	0	0	0	69.28	0	0	13.2
2015	7	24	10	24	8	35	0	0	0	0	0	0	0	69.31	0	0	13.2
2015	7	24	10	34	8	35	0	0	0	0	0	0	0	69.37	0	0	13.2
2015	7	24	10	44	8	35	0	0	0	0	0	0	0	69.4	0	0	13.2
2015	7	24	10	54	8	34	0	0	0	0	0	0	0	69.44	0	0	13.2
2015	7	24	11	4	8	34	0	0	0	0	0	0	0	69.49	0	0	13.2
2015	7	24	11	14	8	34	0	0	0	0	0	0	0	69.53	0	0	13.2
2015	7	24	11	24	8	35	0	0	0	0	0	0	0	69.57	0	0	13.2
2015	7	24	11	34	8	35	0	0	0	0	0	0	0	69.6	0	0	13.2
2015	7	24	11	44	8	35	0	0	0	0	0	0	0	69.62	0	0	13.2
2015	7	24	11	54	8	34	0	0	0	0	0	0	0	69.67	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	24	12	4	8	35	0	0	0	0	0	0	0	69.71	0	0	13.2
2015	7	24	12	14	8	34	0	0	0	0	0	0	0	69.75	0	0	13.2
2015	7	24	12	24	8	35	0	0	0	0	0	0	0	69.76	0	0	13.2
2015	7	24	12	34	8	35	0	0	0	0	0	0	0	69.82	0	0	13.2
2015	7	24	12	44	8	35	0	0	0	0	0	0	0	69.84	0	0	13.2
2015	7	24	12	54	8	35	0	0	0	0	0	0	0	69.85	0	0	13.2
2015	7	24	13	4	8	34	0	0	0	0	0	0	0	69.89	0	0	13.2
2015	7	24	13	14	8	34	0	0	0	0	0	0	0	69.93	0	0	13.2
2015	7	24	13	24	8	35	0	0	0	0	0	0	0	69.94	0	0	13.2
2015	7	24	13	34	8	35	0	0	0	0	0	0	0	69.98	0	0	13.2
2015	7	24	13	44	8	35	0	0	0	0	0	0	0	69.98	0	0	13.2
2015	7	24	13	54	8	34	0	0	0	0	0	0	0	69.98	0	0	13.2
2015	7	24	14	4	8	35	0	0	0	0	0	0	0	70	0	0	13.2
2015	7	24	14	14	8	35	0	0	0	0	0	0	0	70.02	0	0	13.2
2015	7	24	14	24	8	34	0	0	0	0	0	0	0	70.03	0	0	13.2
2015	7	24	14	34	8	34	0	0	0	0	0	0	0	70.05	0	0	13.2
2015	7	24	14	44	8	35	0	0	0	0	0	0	0	70.03	0	0	13.2
2015	7	24	14	54	8	34	0	0	0	0	0	0	0	70.03	0	0	13.2
2015	7	24	15	4	8	35	0	0	0	0	0	0	0	70.05	0	0	13.2
2015	7	24	15	14	8	34	0	0	0	0	0	0	0	70.03	0	0	13.2
2015	7	24	15	24	8	34	0	0	0	0	0	0	0	70.02	0	0	13.2
2015	7	24	15	34	8	35	0	0	0	0	0	0	0	70.03	0	0	13.2
2015	7	24	15	44	8	35	0	0	0	0	0	0	0	70.03	0	0	13.2
2015	7	24	15	54	8	34	0	0	0	0	0	0	0	70.02	0	0	13.2
2015	7	24	16	4	8	34	0	0	0	0	0	0	0	70	0	0	13.2
2015	7	24	16	14	8	34	0	0	0	0	0	0	0	70	0	0	13.2
2015	7	24	16	24	8	34	0	0	0	0	0	0	0	69.98	0	0	13.2
2015	7	24	16	34	8	34	0	0	0	0	0	0	0	69.98	0	0	13
2015	7	24	16	44	8	34	0	0	0	0	0	0	0	69.96	0	0	13.2
2015	7	24	16	54	8	34	0	0	0	0	0	0	0	69.96	0	0	13.2
2015	7	24	17	4	8	35	0	0	0	0	0	0	0	69.96	0	0	13.2
2015	7	24	17	14	8	34	0	0	0	0	0	0	0	69.94	0	0	13
2015	7	24	17	24	8	35	0	0	0	0	0	0	0	69.93	0	0	13
2015	7	24	17	34	8	35	0	0	0	0	0	0	0	69.91	0	0	13
2015	7	24	17	44	8	34	0	0	0	0	0	0	0	69.89	0	0	13.2
2015	7	24	17	54	8	34	0	0	0	0	0	0	0	69.89	0	0	13.2
2015	7	24	18	4	8	34	0	0	0	0	0	0	0	69.89	0	0	13.2
2015	7	24	18	14	8	35	0	0	0	0	0	0	0	69.89	0	0	13.2
2015	7	24	18	24	8	34	0	0	0	0	0	0	0	69.91	0	0	12.8
2015	7	24	18	34	8	35	0	0	0	0	0	0	0	69.93	0	0	12.2
2015	7	24	18	44	8	34	0	0	0	0	0	0	0	69.93	0	0	12.2
2015	7	24	18	54	8	35	0	0	0	0	0	0	0	69.93	0	0	12.2
2015	7	24	19	4	8	34	0	0	0	0	0	0	0	69.94	0	0	12.2
2015	7	24	19	14	8	34	0	0	0	0	0	0	0	69.96	0	0	12.2
2015	7	24	19	24	8	34	0	0	0	0	0	0	0	69.98	0	0	12.2
2015	7	24	19	34	8	34	0	0	0	0	0	0	0	70.02	0	0	12.2
2015	7	24	19	44	8	34	0	0	0	0	0	0	0	70.03	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	24	19	54	8	34		0	0	0	0	0	0	70.05	0	0	12.2
2015	7	24	20	4	8	35		0	0	0	0	0	0	70.07	0	0	12.2
2015	7	24	20	14	8	34		0	0	0	0	0	0	70.09	0	0	12.2
2015	7	24	20	24	8	35		0	0	0	0	0	0	70.11	0	0	12.2
2015	7	24	20	34	8	35		0	0	0	0	0	0	70.12	0	0	12.2
2015	7	24	20	44	8	35		0	0	0	0	0	0	70.14	0	0	12.2
2015	7	24	20	54	8	35		0	0	0	0	0	0	70.16	0	0	12.2
2015	7	24	21	4	8	34		0	0	0	0	0	0	70.18	0	0	12.2
2015	7	24	21	14	8	35		0	0	0	0	0	0	70.18	0	0	12.2
2015	7	24	21	24	8	35		0	0	0	0	0	0	70.2	0	0	12.2
2015	7	24	21	34	8	34		0	0	0	0	0	0	70.21	0	0	12.2
2015	7	24	21	44	8	35		0	0	0	0	0	0	70.23	0	0	12.2
2015	7	24	21	54	8	34		0	0	0	0	0	0	70.23	0	0	12.2
2015	7	24	22	4	8	34		0	0	0	0	0	0	70.25	0	0	12.2
2015	7	24	22	14	8	34		0	0	0	0	0	0	70.25	0	0	12.2
2015	7	24	22	24	8	34		0	0	0	0	0	0	70.27	0	0	12.2
2015	7	24	22	34	8	35		0	0	0	0	0	0	70.27	0	0	12
2015	7	24	22	44	8	34		0	0	0	0	0	0	70.27	0	0	12.2
2015	7	24	22	54	8	35		0	0	0	0	0	0	70.29	0	0	12.2
2015	7	24	23	4	8	35		0	0	0	0	0	0	70.29	0	0	12.2
2015	7	24	23	14	8	34		0	0	0	0	0	0	70.29	0	0	12
2015	7	24	23	24	8	35		0	0	0	0	0	0	70.27	0	0	12
2015	7	24	23	34	8	34		0	0	0	0	0	0	70.27	0	0	12
2015	7	24	23	44	8	34		0	0	0	0	0	0	70.25	0	0	12
2015	7	24	23	54	8	35		0	0	0	0	0	0	70.25	0	0	12
2015	7	25	0	4	8	35		0	0	0	0	0	0	70.25	0	0	12
2015	7	25	0	14	8	34		0	0	0	0	0	0	70.25	0	0	12
2015	7	25	0	24	8	34		0	0	0	0	0	0	70.23	0	0	12
2015	7	25	0	34	8	34		0	0	0	0	0	0	70.21	0	0	12
2015	7	25	0	44	8	34		0	0	0	0	0	0	70.2	0	0	12
2015	7	25	0	54	8	34		0	0	0	0	0	0	70.18	0	0	12
2015	7	25	1	4	8	34		0	0	0	0	0	0	70.18	0	0	12
2015	7	25	1	14	8	34		0	0	0	0	0	0	70.16	0	0	12
2015	7	25	1	24	8	34		0	0	0	0	0	0	70.14	0	0	12
2015	7	25	1	34	8	35		0	0	0	0	0	0	70.11	0	0	12
2015	7	25	1	44	8	34		0	0	0	0	0	0	70.09	0	0	12
2015	7	25	1	54	8	34		0	0	0	0	0	0	70.05	0	0	12
2015	7	25	2	4	8	35		0	0	0	0	0	0	70.02	0	0	12
2015	7	25	2	14	8	35		0	0	0	0	0	0	70	0	0	12
2015	7	25	2	24	8	34		0	0	0	0	0	0	69.96	0	0	12
2015	7	25	2	34	8	35		0	0	0	0	0	0	69.93	0	0	12
2015	7	25	2	44	8	34		0	0	0	0	0	0	69.89	0	0	12
2015	7	25	2	54	8	34		0	0	0	0	0	0	69.85	0	0	12
2015	7	25	3	4	8	35		0	0	0	0	0	0	69.8	0	0	12
2015	7	25	3	14	8	34		0	0	0	0	0	0	69.76	0	0	12
2015	7	25	3	24	8	34		0	0	0	0	0	0	69.73	0	0	12
2015	7	25	3	34	8	34		0	0	0	0	0	0	69.69	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	25	3	44	8	34		0	0	0	0	0	0	69.64	0	0	12
2015	7	25	3	54	8	34		0	0	0	0	0	0	69.58	0	0	12
2015	7	25	4	4	8	34		0	0	0	0	0	0	69.55	0	0	12
2015	7	25	4	14	8	34		0	0	0	0	0	0	69.51	0	0	12
2015	7	25	4	24	8	34		0	0	0	0	0	0	69.46	0	0	12
2015	7	25	4	34	8	35		0	0	0	0	0	0	69.42	0	0	12
2015	7	25	4	44	8	34		0	0	0	0	0	0	69.37	0	0	12
2015	7	25	4	54	8	34		0	0	0	0	0	0	69.33	0	0	12
2015	7	25	5	4	8	34		0	0	0	0	0	0	69.28	0	0	12
2015	7	25	5	14	8	35		0	0	0	0	0	0	69.24	0	0	12
2015	7	25	5	24	8	34		0	0	0	0	0	0	69.19	0	0	12
2015	7	25	5	34	8	34		0	0	0	0	0	0	69.15	0	0	11.8
2015	7	25	5	44	8	35		0	0	0	0	0	0	69.1	0	0	12
2015	7	25	5	54	8	35		0	0	0	0	0	0	69.06	0	0	12
2015	7	25	6	4	8	34		0	0	0	0	0	0	69.01	0	0	12
2015	7	25	6	14	8	35		0	0	0	0	0	0	68.99	0	0	12
2015	7	25	6	24	8	35		0	0	0	0	0	0	68.94	0	0	12
2015	7	25	6	34	8	35		0	0	0	0	0	0	68.9	0	0	11.8
2015	7	25	6	44	8	35		0	0	0	0	0	0	68.86	0	0	12
2015	7	25	6	54	8	35		0	0	0	0	0	0	68.83	0	0	12
2015	7	25	7	4	8	35		0	0	0	0	0	0	68.79	0	0	12.2
2015	7	25	7	14	8	35		0	0	0	0	0	0	68.76	0	0	12.2
2015	7	25	7	24	8	36		0	0	0	0	0	0	68.74	0	0	12.2
2015	7	25	7	34	8	35		0	0	0	0	0	0	68.72	0	0	12.4
2015	7	25	7	44	8	34		0	0	0	0	0	0	68.72	0	0	12.6
2015	7	25	7	54	8	35		0	0	0	0	0	0	68.72	0	0	12.6
2015	7	25	8	4	8	35		0	0	0	0	0	0	68.72	0	0	12.6
2015	7	25	8	14	8	35		0	0	0	0	0	0	68.72	0	0	12.8
2015	7	25	8	24	8	34		0	0	0	0	0	0	68.72	0	0	12.8
2015	7	25	8	34	8	35		0	0	0	0	0	0	68.74	0	0	12.8
2015	7	25	8	44	8	34		0	0	0	0	0	0	68.74	0	0	12.8
2015	7	25	8	54	8	35		0	0	0	0	0	0	68.77	0	0	13
2015	7	25	9	4	8	35		0	0	0	0	0	0	68.79	0	0	13
2015	7	25	9	14	8	35		0	0	0	0	0	0	68.81	0	0	13
2015	7	25	9	24	8	34		0	0	0	0	0	0	68.83	0	0	13.2
2015	7	25	9	34	8	35		0	0	0	0	0	0	68.86	0	0	13.2
2015	7	25	9	44	8	35		0	0	0	0	0	0	68.88	0	0	13.2
2015	7	25	9	54	8	34		0	0	0	0	0	0	68.92	0	0	13.2
2015	7	25	10	4	8	34		0	0	0	0	0	0	68.95	0	0	13.2
2015	7	25	10	14	8	35		0	0	0	0	0	0	68.99	0	0	13.2
2015	7	25	10	24	8	34		0	0	0	0	0	0	69.03	0	0	13
2015	7	25	10	34	8	35		0	0	0	0	0	0	69.06	0	0	13
2015	7	25	10	44	8	34		0	0	0	0	0	0	69.1	0	0	13
2015	7	25	10	54	8	34		0	0	0	0	0	0	69.13	0	0	13
2015	7	25	11	4	8	35		0	0	0	0	0	0	69.19	0	0	13
2015	7	25	11	14	8	35		0	0	0	0	0	0	69.21	0	0	13
2015	7	25	11	24	8	35		0	0	0	0	0	0	69.24	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	25	11	34	8	34	0	0	0	0	0	0	0	69.28	0	0	13
2015	7	25	11	44	8	35	0	0	0	0	0	0	0	69.33	0	0	13.2
2015	7	25	11	54	8	34	0	0	0	0	0	0	0	69.35	0	0	13.2
2015	7	25	12	4	8	34	0	0	0	0	0	0	0	69.48	0	0	13.2
2015	7	25	12	14	8	34	0	0	0	0	0	0	0	69.53	0	0	13.2
2015	7	25	12	24	8	34	0	0	0	0	0	0	0	69.55	0	0	13.2
2015	7	25	12	34	8	35	0	0	0	0	0	0	0	69.57	0	0	13.2
2015	7	25	12	44	8	35	0	0	0	0	0	0	0	69.62	0	0	13.2
2015	7	25	12	54	8	34	0	0	0	0	0	0	0	69.66	0	0	13.2
2015	7	25	13	4	8	33	0	0	0	0	0	0	0	69.67	0	0	13.2
2015	7	25	13	14	8	34	0	0	0	0	0	0	0	69.69	0	0	13.2
2015	7	25	13	24	8	34	0	0	0	0	0	0	0	69.69	0	0	13.2
2015	7	25	13	34	8	34	0	0	0	0	0	0	0	69.71	0	0	13.2
2015	7	25	13	44	8	34	0	0	0	0	0	0	0	69.73	0	0	13.2
2015	7	25	13	54	8	34	0	0	0	0	0	0	0	69.75	0	0	13.2
2015	7	25	14	4	8	35	0	0	0	0	0	0	0	69.73	0	0	13.2
2015	7	25	14	14	8	35	0	0	0	0	0	0	0	69.75	0	0	13.2
2015	7	25	14	24	8	34	0	0	0	0	0	0	0	69.75	0	0	13.2
2015	7	25	14	34	8	35	0	0	0	0	0	0	0	69.76	0	0	13.2
2015	7	25	14	44	8	35	0	0	0	0	0	0	0	69.75	0	0	13.2
2015	7	25	14	54	8	35	0	0	0	0	0	0	0	69.71	0	0	13.2
2015	7	25	15	4	8	34	0	0	0	0	0	0	0	69.71	0	0	13.2
2015	7	25	15	14	8	35	0	0	0	0	0	0	0	69.73	0	0	13.2
2015	7	25	15	24	8	34	0	0	0	0	0	0	0	69.71	0	0	13.2
2015	7	25	15	34	8	35	0	0	0	0	0	0	0	69.69	0	0	13.2
2015	7	25	15	44	8	35	0	0	0	0	0	0	0	69.67	0	0	13.2
2015	7	25	15	54	8	34	0	0	0	0	0	0	0	69.67	0	0	13.2
2015	7	25	16	4	8	35	0	0	0	0	0	0	0	69.66	0	0	13.2
2015	7	25	16	14	8	35	0	0	0	0	0	0	0	69.64	0	0	13.2
2015	7	25	16	24	8	34	0	0	0	0	0	0	0	69.62	0	0	13.2
2015	7	25	16	34	8	35	0	0	0	0	0	0	0	69.6	0	0	13.2
2015	7	25	16	44	8	34	0	0	0	0	0	0	0	69.58	0	0	13.2
2015	7	25	16	54	8	35	0	0	0	0	0	0	0	69.58	0	0	13.2
2015	7	25	17	4	8	35	0	0	0	0	0	0	0	69.55	0	0	13.2
2015	7	25	17	14	8	34	0	0	0	0	0	0	0	69.55	0	0	13.2
2015	7	25	17	24	8	35	0	0	0	0	0	0	0	69.53	0	0	13.2
2015	7	25	17	34	8	35	0	0	0	0	0	0	0	69.51	0	0	13
2015	7	25	17	44	8	35	0	0	0	0	0	0	0	69.49	0	0	13.2
2015	7	25	17	54	8	35	0	0	0	0	0	0	0	69.48	0	0	13.2
2015	7	25	18	4	8	35	0	0	0	0	0	0	0	69.48	0	0	13.2
2015	7	25	18	14	8	35	0	0	0	0	0	0	0	69.48	0	0	13.2
2015	7	25	18	24	8	35	0	0	0	0	0	0	0	69.49	0	0	12.8
2015	7	25	18	34	8	34	0	0	0	0	0	0	0	69.49	0	0	12.2
2015	7	25	18	44	8	35	0	0	0	0	0	0	0	69.51	0	0	12.2
2015	7	25	18	54	8	34	0	0	0	0	0	0	0	69.53	0	0	12.2
2015	7	25	19	4	8	34	0	0	0	0	0	0	0	69.55	0	0	12.2
2015	7	25	19	14	8	34	0	0	0	0	0	0	0	69.57	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	25	19	24	8	35		0	0	0	0	0	0	69.58	0	0	12.2
2015	7	25	19	34	8	34		0	0	0	0	0	0	69.6	0	0	12.2
2015	7	25	19	44	8	34		0	0	0	0	0	0	69.62	0	0	12.2
2015	7	25	19	54	8	34		0	0	0	0	0	0	69.64	0	0	12.2
2015	7	25	20	4	8	34		0	0	0	0	0	0	69.66	0	0	12.2
2015	7	25	20	14	8	34		0	0	0	0	0	0	69.69	0	0	12.2
2015	7	25	20	24	8	34		0	0	0	0	0	0	69.71	0	0	12.2
2015	7	25	20	34	8	34		0	0	0	0	0	0	69.73	0	0	12.2
2015	7	25	20	44	8	35		0	0	0	0	0	0	69.75	0	0	12.2
2015	7	25	20	54	8	34		0	0	0	0	0	0	69.76	0	0	12.2
2015	7	25	21	4	8	35		0	0	0	0	0	0	69.78	0	0	12.2
2015	7	25	21	14	8	35		0	0	0	0	0	0	69.8	0	0	12.2
2015	7	25	21	24	8	35		0	0	0	0	0	0	69.82	0	0	12.2
2015	7	25	21	34	8	35		0	0	0	0	0	0	69.84	0	0	12.2
2015	7	25	21	44	8	35		0	0	0	0	0	0	69.85	0	0	12.2
2015	7	25	21	54	8	35		0	0	0	0	0	0	69.87	0	0	12.2
2015	7	25	22	4	8	35		0	0	0	0	0	0	69.87	0	0	12.2
2015	7	25	22	14	8	35		0	0	0	0	0	0	69.89	0	0	12.2
2015	7	25	22	24	8	35		0	0	0	0	0	0	69.89	0	0	12.2
2015	7	25	22	34	8	35		0	0	0	0	0	0	69.89	0	0	12.2
2015	7	25	22	44	8	34		0	0	0	0	0	0	69.89	0	0	12.2
2015	7	25	22	54	8	34		0	0	0	0	0	0	69.91	0	0	12.2
2015	7	25	23	4	8	35		0	0	0	0	0	0	69.89	0	0	12.2
2015	7	25	23	14	8	34		0	0	0	0	0	0	69.89	0	0	12
2015	7	25	23	24	8	34		0	0	0	0	0	0	69.91	0	0	12
2015	7	25	23	34	8	35		0	0	0	0	0	0	69.89	0	0	12
2015	7	25	23	44	8	35		0	0	0	0	0	0	69.89	0	0	12
2015	7	25	23	54	8	34		0	0	0	0	0	0	69.87	0	0	12
2015	7	26	0	4	8	35		0	0	0	0	0	0	69.87	0	0	12
2015	7	26	0	14	8	34		0	0	0	0	0	0	69.85	0	0	12
2015	7	26	0	24	8	35		0	0	0	0	0	0	69.84	0	0	12
2015	7	26	0	34	8	35		0	0	0	0	0	0	69.82	0	0	12
2015	7	26	0	44	8	34		0	0	0	0	0	0	69.8	0	0	12
2015	7	26	0	54	8	34		0	0	0	0	0	0	69.8	0	0	12
2015	7	26	1	4	8	34		0	0	0	0	0	0	69.76	0	0	12
2015	7	26	1	14	8	35		0	0	0	0	0	0	69.75	0	0	12
2015	7	26	1	24	8	34		0	0	0	0	0	0	69.73	0	0	12
2015	7	26	1	34	8	34		0	0	0	0	0	0	69.69	0	0	12
2015	7	26	1	44	8	35		0	0	0	0	0	0	69.66	0	0	12
2015	7	26	1	54	8	34		0	0	0	0	0	0	69.64	0	0	12
2015	7	26	2	4	8	34		0	0	0	0	0	0	69.6	0	0	12
2015	7	26	2	14	8	35		0	0	0	0	0	0	69.57	0	0	12
2015	7	26	2	24	8	34		0	0	0	0	0	0	69.53	0	0	12
2015	7	26	2	34	8	34		0	0	0	0	0	0	69.51	0	0	12
2015	7	26	2	44	8	34		0	0	0	0	0	0	69.44	0	0	12
2015	7	26	2	54	8	34		0	0	0	0	0	0	69.42	0	0	12
2015	7	26	3	4	8	34		0	0	0	0	0	0	69.37	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	26	3	14	8	35		0	0	0	0	0	0	69.31	0	0	12
2015	7	26	3	24	8	34		0	0	0	0	0	0	69.28	0	0	12
2015	7	26	3	34	8	34		0	0	0	0	0	0	69.22	0	0	12
2015	7	26	3	44	8	35		0	0	0	0	0	0	69.19	0	0	12
2015	7	26	3	54	8	35		0	0	0	0	0	0	69.13	0	0	12
2015	7	26	4	4	8	35		0	0	0	0	0	0	69.08	0	0	12
2015	7	26	4	14	8	35		0	0	0	0	0	0	69.03	0	0	12
2015	7	26	4	24	8	35		0	0	0	0	0	0	68.99	0	0	12
2015	7	26	4	34	8	35		0	0	0	0	0	0	68.92	0	0	12
2015	7	26	4	44	8	34		0	0	0	0	0	0	68.86	0	0	12
2015	7	26	4	54	8	35		0	0	0	0	0	0	68.81	0	0	12
2015	7	26	5	4	8	35		0	0	0	0	0	0	68.76	0	0	12
2015	7	26	5	14	8	34		0	0	0	0	0	0	68.7	0	0	12
2015	7	26	5	24	8	35		0	0	0	0	0	0	68.65	0	0	12
2015	7	26	5	34	8	35		0	0	0	0	0	0	68.61	0	0	12
2015	7	26	5	44	8	35		0	0	0	0	0	0	68.54	0	0	12
2015	7	26	5	54	8	35		0	0	0	0	0	0	68.5	0	0	12
2015	7	26	6	4	8	35		0	0	0	0	0	0	68.45	0	0	12
2015	7	26	6	14	8	35		0	0	0	0	0	0	68.41	0	0	12
2015	7	26	6	24	8	35		0	0	0	0	0	0	68.36	0	0	12
2015	7	26	6	34	8	34		0	0	0	0	0	0	68.32	0	0	12
2015	7	26	6	44	8	34		0	0	0	0	0	0	68.27	0	0	12
2015	7	26	6	54	8	35		0	0	0	0	0	0	68.23	0	0	12
2015	7	26	7	4	8	35		0	0	0	0	0	0	68.2	0	0	12.2
2015	7	26	7	14	8	35		0	0	0	0	0	0	68.16	0	0	12.2
2015	7	26	7	24	8	34		0	0	0	0	0	0	68.13	0	0	12.4
2015	7	26	7	34	8	35		0	0	0	0	0	0	68.13	0	0	12.4
2015	7	26	7	44	8	35		0	0	0	0	0	0	68.11	0	0	12.6
2015	7	26	7	54	8	35		0	0	0	0	0	0	68.13	0	0	12.6
2015	7	26	8	4	8	34		0	0	0	0	0	0	68.11	0	0	12.8
2015	7	26	8	14	8	34		0	0	0	0	0	0	68.11	0	0	12.8
2015	7	26	8	24	8	34		0	0	0	0	0	0	68.13	0	0	12.8
2015	7	26	8	34	8	35		0	0	0	0	0	0	68.13	0	0	12.8
2015	7	26	8	44	8	35		0	0	0	0	0	0	68.14	0	0	12.8
2015	7	26	8	54	8	35		0	0	0	0	0	0	68.16	0	0	13
2015	7	26	9	4	8	35		0	0	0	0	0	0	68.18	0	0	13
2015	7	26	9	14	8	34		0	0	0	0	0	0	68.22	0	0	13.2
2015	7	26	9	24	8	35		0	0	0	0	0	0	68.23	0	0	13.2
2015	7	26	9	34	8	34		0	0	0	0	0	0	68.27	0	0	13.2
2015	7	26	9	44	8	34		0	0	0	0	0	0	68.31	0	0	13.2
2015	7	26	9	54	8	35		0	0	0	0	0	0	68.34	0	0	13.2
2015	7	26	10	4	8	34		0	0	0	0	0	0	68.38	0	0	13
2015	7	26	10	14	8	34		0	0	0	0	0	0	68.41	0	0	13
2015	7	26	10	24	8	36		0	0	0	0	0	0	68.45	0	0	13
2015	7	26	10	34	8	36		0	0	0	0	0	0	68.49	0	0	13
2015	7	26	10	44	8	35		0	0	0	0	0	0	68.54	0	0	13
2015	7	26	10	54	8	35		0	0	0	0	0	0	68.58	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	26	11	4	8	34	0	0	0	0	0	0	0	68.63	0	0	13
2015	7	26	11	14	8	34	0	0	0	0	0	0	0	68.67	0	0	13
2015	7	26	11	24	8	34	0	0	0	0	0	0	0	68.68	0	0	13.2
2015	7	26	11	34	8	35	0	0	0	0	0	0	0	68.74	0	0	13.2
2015	7	26	11	44	8	35	0	0	0	0	0	0	0	68.79	0	0	13.2
2015	7	26	11	54	8	35	0	0	0	0	0	0	0	68.81	0	0	13.2
2015	7	26	12	4	8	35	0	0	0	0	0	0	0	68.85	0	0	13.2
2015	7	26	12	14	8	35	0	0	0	0	0	0	0	68.9	0	0	13.2
2015	7	26	12	24	8	34	0	0	0	0	0	0	0	68.94	0	0	13.2
2015	7	26	12	34	8	34	0	0	0	0	0	0	0	68.95	0	0	13.2
2015	7	26	12	44	8	34	0	0	0	0	0	0	0	68.99	0	0	13.2
2015	7	26	12	54	8	35	0	0	0	0	0	0	0	69.01	0	0	13.2
2015	7	26	13	4	8	35	0	0	0	0	0	0	0	69.03	0	0	13.2
2015	7	26	13	14	8	34	0	0	0	0	0	0	0	69.06	0	0	13.2
2015	7	26	13	24	8	35	0	0	0	0	0	0	0	69.06	0	0	13.2
2015	7	26	13	34	8	35	0	0	0	0	0	0	0	69.1	0	0	13.2
2015	7	26	13	44	8	35	0	0	0	0	0	0	0	69.1	0	0	13.2
2015	7	26	13	54	8	35	0	0	0	0	0	0	0	69.17	0	0	13.2
2015	7	26	14	4	8	35	0	0	0	0	0	0	0	69.19	0	0	13.2
2015	7	26	14	14	8	35	0	0	0	0	0	0	0	69.22	0	0	13.2
2015	7	26	14	24	8	35	0	0	0	0	0	0	0	69.21	0	0	13.2
2015	7	26	14	34	8	35	0	0	0	0	0	0	0	69.22	0	0	13.2
2015	7	26	14	44	8	34	0	0	0	0	0	0	0	69.21	0	0	13.2
2015	7	26	14	54	8	34	0	0	0	0	0	0	0	69.19	0	0	13.2
2015	7	26	15	4	8	35	0	0	0	0	0	0	0	69.17	0	0	13.2
2015	7	26	15	14	8	34	0	0	0	0	0	0	0	69.17	0	0	13.2
2015	7	26	15	24	8	34	0	0	0	0	0	0	0	69.15	0	0	13.2
2015	7	26	15	34	8	35	0	0	0	0	0	0	0	69.13	0	0	13.2
2015	7	26	15	44	8	34	0	0	0	0	0	0	0	69.1	0	0	13.2
2015	7	26	15	54	8	35	0	0	0	0	0	0	0	69.1	0	0	13.2
2015	7	26	16	4	8	35	0	0	0	0	0	0	0	69.06	0	0	13.2
2015	7	26	16	14	8	35	0	0	0	0	0	0	0	69.04	0	0	13.2
2015	7	26	16	24	8	34	0	0	0	0	0	0	0	69.03	0	0	13.2
2015	7	26	16	34	8	35	0	0	0	0	0	0	0	69.01	0	0	13.2
2015	7	26	16	44	8	35	0	0	0	0	0	0	0	68.99	0	0	13.2
2015	7	26	16	54	8	35	0	0	0	0	0	0	0	68.99	0	0	13.2
2015	7	26	17	4	8	35	0	0	0	0	0	0	0	68.97	0	0	13.2
2015	7	26	17	14	8	35	0	0	0	0	0	0	0	68.95	0	0	13.2
2015	7	26	17	24	8	35	0	0	0	0	0	0	0	68.92	0	0	13.2
2015	7	26	17	34	8	34	0	0	0	0	0	0	0	68.92	0	0	13
2015	7	26	17	44	8	34	0	0	0	0	0	0	0	68.88	0	0	13.2
2015	7	26	17	54	8	34	0	0	0	0	0	0	0	68.88	0	0	13.2
2015	7	26	18	4	8	35	0	0	0	0	0	0	0	68.86	0	0	13.2
2015	7	26	18	14	8	35	0	0	0	0	0	0	0	68.88	0	0	13
2015	7	26	18	24	8	35	0	0	0	0	0	0	0	68.88	0	0	12.8
2015	7	26	18	34	8	35	0	0	0	0	0	0	0	68.9	0	0	12.4
2015	7	26	18	44	8	35	0	0	0	0	0	0	0	68.92	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	26	18	54	8	35		0	0	0	0	0	0	68.92	0	0	12.2
2015	7	26	19	4	8	35		0	0	0	0	0	0	68.94	0	0	12.2
2015	7	26	19	14	8	34		0	0	0	0	0	0	68.95	0	0	12.2
2015	7	26	19	24	8	35		0	0	0	0	0	0	68.97	0	0	12.2
2015	7	26	19	34	8	35		0	0	0	0	0	0	69.01	0	0	12.2
2015	7	26	19	44	8	35		0	0	0	0	0	0	69.01	0	0	12.2
2015	7	26	19	54	8	34		0	0	0	0	0	0	69.03	0	0	12.2
2015	7	26	20	4	8	35		0	0	0	0	0	0	69.04	0	0	12.2
2015	7	26	20	14	8	35		0	0	0	0	0	0	69.06	0	0	12.2
2015	7	26	20	24	8	34		0	0	0	0	0	0	69.08	0	0	12.2
2015	7	26	20	34	8	34		0	0	0	0	0	0	69.1	0	0	12.2
2015	7	26	20	44	8	34		0	0	0	0	0	0	69.12	0	0	12.2
2015	7	26	20	54	8	34		0	0	0	0	0	0	69.15	0	0	12.2
2015	7	26	21	4	8	34		0	0	0	0	0	0	69.17	0	0	12.2
2015	7	26	21	14	8	35		0	0	0	0	0	0	69.19	0	0	12.2
2015	7	26	21	24	8	35		0	0	0	0	0	0	69.21	0	0	12.2
2015	7	26	21	34	8	35		0	0	0	0	0	0	69.22	0	0	12.2
2015	7	26	21	44	8	35		0	0	0	0	0	0	69.24	0	0	12.2
2015	7	26	21	54	8	34		0	0	0	0	0	0	69.24	0	0	12.2
2015	7	26	22	4	8	35		0	0	0	0	0	0	69.26	0	0	12.2
2015	7	26	22	14	8	34		0	0	0	0	0	0	69.28	0	0	12.2
2015	7	26	22	24	8	35		0	0	0	0	0	0	69.28	0	0	12.2
2015	7	26	22	34	8	34		0	0	0	0	0	0	69.28	0	0	12.2
2015	7	26	22	44	8	34		0	0	0	0	0	0	69.28	0	0	12.2
2015	7	26	22	54	8	35		0	0	0	0	0	0	69.3	0	0	12.2
2015	7	26	23	4	8	35		0	0	0	0	0	0	69.3	0	0	12.2
2015	7	26	23	14	8	34		0	0	0	0	0	0	69.28	0	0	12
2015	7	26	23	24	8	34		0	0	0	0	0	0	69.28	0	0	12
2015	7	26	23	34	8	34		0	0	0	0	0	0	69.28	0	0	12
2015	7	26	23	44	8	35		0	0	0	0	0	0	69.28	0	0	12
2015	7	26	23	54	8	35		0	0	0	0	0	0	69.26	0	0	12
2015	7	27	0	4	8	35		0	0	0	0	0	0	69.26	0	0	12
2015	7	27	0	14	8	34		0	0	0	0	0	0	69.24	0	0	12
2015	7	27	0	24	8	34		0	0	0	0	0	0	69.22	0	0	12
2015	7	27	0	34	8	34		0	0	0	0	0	0	69.21	0	0	12
2015	7	27	0	44	8	34		0	0	0	0	0	0	69.19	0	0	12
2015	7	27	0	54	8	35		0	0	0	0	0	0	69.15	0	0	12
2015	7	27	1	4	8	35		0	0	0	0	0	0	69.13	0	0	12
2015	7	27	1	14	8	34		0	0	0	0	0	0	69.12	0	0	12
2015	7	27	1	24	8	34		0	0	0	0	0	0	69.08	0	0	12
2015	7	27	1	34	8	34		0	0	0	0	0	0	69.06	0	0	12
2015	7	27	1	44	8	35		0	0	0	0	0	0	69.03	0	0	12
2015	7	27	1	54	8	34		0	0	0	0	0	0	69.01	0	0	12
2015	7	27	2	4	8	35		0	0	0	0	0	0	68.97	0	0	12
2015	7	27	2	14	8	34		0	0	0	0	0	0	68.95	0	0	12
2015	7	27	2	24	8	34		0	0	0	0	0	0	68.9	0	0	12
2015	7	27	2	34	8	35		0	0	0	0	0	0	68.88	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	27	2	44	8	34		0	0	0	0	0	0	68.86	0	0	12
2015	7	27	2	54	8	35		0	0	0	0	0	0	68.85	0	0	12
2015	7	27	3	4	8	34		0	0	0	0	0	0	68.81	0	0	12
2015	7	27	3	14	8	34		0	0	0	0	0	0	68.79	0	0	12
2015	7	27	3	24	8	34		0	0	0	0	0	0	68.76	0	0	12
2015	7	27	3	34	8	35		0	0	0	0	0	0	68.72	0	0	12
2015	7	27	3	44	8	35		0	0	0	0	0	0	68.7	0	0	12
2015	7	27	3	54	8	35		0	0	0	0	0	0	68.67	0	0	12
2015	7	27	4	4	8	35		0	0	0	0	0	0	68.63	0	0	12
2015	7	27	4	14	8	34		0	0	0	0	0	0	68.61	0	0	12
2015	7	27	4	24	8	35		0	0	0	0	0	0	68.58	0	0	12
2015	7	27	4	34	8	34		0	0	0	0	0	0	68.56	0	0	12
2015	7	27	4	44	8	35		0	0	0	0	0	0	68.54	0	0	12
2015	7	27	4	54	8	35		0	0	0	0	0	0	68.5	0	0	12
2015	7	27	5	4	8	35		0	0	0	0	0	0	68.49	0	0	12
2015	7	27	5	14	8	34		0	0	0	0	0	0	68.47	0	0	12
2015	7	27	5	24	8	34		0	0	0	0	0	0	68.43	0	0	12
2015	7	27	5	34	8	35		0	0	0	0	0	0	68.41	0	0	12
2015	7	27	5	44	8	34		0	0	0	0	0	0	68.4	0	0	12
2015	7	27	5	54	8	35		0	0	0	0	0	0	68.38	0	0	12
2015	7	27	6	4	8	34		0	0	0	0	0	0	68.34	0	0	12
2015	7	27	6	14	8	35		0	0	0	0	0	0	68.32	0	0	12
2015	7	27	6	24	8	35		0	0	0	0	0	0	68.31	0	0	12
2015	7	27	6	34	8	34		0	0	0	0	0	0	68.29	0	0	12
2015	7	27	6	44	8	35		0	0	0	0	0	0	68.25	0	0	12
2015	7	27	6	54	8	35		0	0	0	0	0	0	68.25	0	0	12
2015	7	27	7	4	8	34		0	0	0	0	0	0	68.22	0	0	12.2
2015	7	27	7	14	8	34		0	0	0	0	0	0	68.2	0	0	12.2
2015	7	27	7	24	8	34		0	0	0	0	0	0	68.18	0	0	12.2
2015	7	27	7	34	8	35		0	0	0	0	0	0	68.18	0	0	12.4
2015	7	27	7	44	8	34		0	0	0	0	0	0	68.18	0	0	12.4
2015	7	27	7	54	8	34		0	0	0	0	0	0	68.14	0	0	12.6
2015	7	27	8	4	8	35		0	0	0	0	0	0	68.14	0	0	12.6
2015	7	27	8	14	8	35		0	0	0	0	0	0	68.13	0	0	12.6
2015	7	27	8	24	8	34		0	0	0	0	0	0	68.13	0	0	12.8
2015	7	27	8	34	8	35		0	0	0	0	0	0	68.13	0	0	12.8
2015	7	27	8	44	8	34		0	0	0	0	0	0	68.11	0	0	12.8
2015	7	27	8	54	8	34		0	0	0	0	0	0	68.11	0	0	12.8
2015	7	27	9	4	8	35		0	0	0	0	0	0	68.13	0	0	13
2015	7	27	9	14	8	34		0	0	0	0	0	0	68.16	0	0	13
2015	7	27	9	24	8	35		0	0	0	0	0	0	68.18	0	0	13.4
2015	7	27	9	34	8	35		0	0	0	0	0	0	68.18	0	0	13.4
2015	7	27	9	44	8	35		0	0	0	0	0	0	68.2	0	0	13.4
2015	7	27	9	54	8	35		0	0	0	0	0	0	68.22	0	0	13.4
2015	7	27	10	4	8	34		0	0	0	0	0	0	68.25	0	0	13.4
2015	7	27	10	14	8	34		0	0	0	0	0	0	68.27	0	0	13.4
2015	7	27	10	24	8	35		0	0	0	0	0	0	68.29	0	0	13.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	27	10	34	8	35		0	0	0	0	0	0	68.32	0	0	13.4
2015	7	27	10	44	8	35		0	0	0	0	0	0	68.36	0	0	13.4
2015	7	27	10	54	8	34		0	0	0	0	0	0	68.38	0	0	13.4
2015	7	27	11	4	8	35		0	0	0	0	0	0	68.4	0	0	13.4
2015	7	27	11	14	8	35		0	0	0	0	0	0	68.43	0	0	13.4
2015	7	27	11	24	8	34		0	0	0	0	0	0	68.47	0	0	13.4
2015	7	27	11	34	8	35		0	0	0	0	0	0	68.5	0	0	13.2
2015	7	27	11	44	8	35		0	0	0	0	0	0	68.56	0	0	13.2
2015	7	27	11	54	8	35		0	0	0	0	0	0	68.59	0	0	13.2
2015	7	27	12	4	8	35		0	0	0	0	0	0	68.61	0	0	13.2
2015	7	27	12	14	8	35		0	0	0	0	0	0	68.65	0	0	13.2
2015	7	27	12	24	8	35		0	0	0	0	0	0	68.67	0	0	13.2
2015	7	27	12	34	8	34		0	0	0	0	0	0	68.7	0	0	13.2
2015	7	27	12	44	8	34		0	0	0	0	0	0	68.72	0	0	13.2
2015	7	27	12	54	8	35		0	0	0	0	0	0	68.76	0	0	13.2
2015	7	27	13	4	8	35		0	0	0	0	0	0	68.77	0	0	13.2
2015	7	27	13	14	8	34		0	0	0	0	0	0	68.79	0	0	13.2
2015	7	27	13	24	8	35		0	0	0	0	0	0	68.81	0	0	13.2
2015	7	27	13	34	8	34		0	0	0	0	0	0	68.81	0	0	13.2
2015	7	27	13	44	8	35		0	0	0	0	0	0	68.83	0	0	13.2
2015	7	27	13	54	8	35		0	0	0	0	0	0	68.85	0	0	13.2
2015	7	27	14	4	8	34		0	0	0	0	0	0	68.85	0	0	13.2
2015	7	27	14	14	8	34		0	0	0	0	0	0	68.85	0	0	13.2
2015	7	27	14	24	8	35		0	0	0	0	0	0	68.86	0	0	13.2
2015	7	27	14	34	8	35		0	0	0	0	0	0	68.85	0	0	13.2
2015	7	27	14	44	8	34		0	0	0	0	0	0	68.85	0	0	13.2
2015	7	27	14	54	8	35		0	0	0	0	0	0	68.83	0	0	13.2
2015	7	27	15	4	8	35		0	0	0	0	0	0	68.83	0	0	13
2015	7	27	15	14	8	35		0	0	0	0	0	0	68.79	0	0	13
2015	7	27	15	24	8	34		0	0	0	0	0	0	68.77	0	0	13
2015	7	27	15	34	8	33		0	0	0	0	0	0	68.76	0	0	13
2015	7	27	15	44	8	34		0	0	0	0	0	0	68.74	0	0	13
2015	7	27	15	54	8	35		0	0	0	0	0	0	68.74	0	0	13
2015	7	27	16	4	8	34		0	0	0	0	0	0	68.72	0	0	13
2015	7	27	16	14	8	35		0	0	0	0	0	0	68.7	0	0	13
2015	7	27	16	24	8	35		0	0	0	0	0	0	68.68	0	0	13
2015	7	27	16	34	8	35		0	0	0	0	0	0	68.67	0	0	13
2015	7	27	16	44	8	35		0	0	0	0	0	0	68.65	0	0	13
2015	7	27	16	54	8	34		0	0	0	0	0	0	68.65	0	0	13
2015	7	27	17	4	8	35		0	0	0	0	0	0	68.63	0	0	13
2015	7	27	17	14	8	35		0	0	0	0	0	0	68.63	0	0	13
2015	7	27	17	24	8	34		0	0	0	0	0	0	68.61	0	0	13
2015	7	27	17	34	8	35		0	0	0	0	0	0	68.59	0	0	12.8
2015	7	27	17	44	8	34		0	0	0	0	0	0	68.56	0	0	13
2015	7	27	17	54	8	35		0	0	0	0	0	0	68.56	0	0	13
2015	7	27	18	4	8	34		0	0	0	0	0	0	68.56	0	0	13
2015	7	27	18	14	8	35		0	0	0	0	0	0	68.56	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	27	18	24	8	34	0	0	0	0	0	0	0	68.56	0	0	12.8
2015	7	27	18	34	8	35	0	0	0	0	0	0	0	68.58	0	0	12.2
2015	7	27	18	44	8	34	0	0	0	0	0	0	0	68.58	0	0	12.2
2015	7	27	18	54	8	35	0	0	0	0	0	0	0	68.59	0	0	12.2
2015	7	27	19	4	8	35	0	0	0	0	0	0	0	68.61	0	0	12.2
2015	7	27	19	14	8	34	0	0	0	0	0	0	0	68.61	0	0	12.2
2015	7	27	19	24	8	34	0	0	0	0	0	0	0	68.63	0	0	12.2
2015	7	27	19	34	8	35	0	0	0	0	0	0	0	68.65	0	0	12.2
2015	7	27	19	44	8	34	0	0	0	0	0	0	0	68.67	0	0	12.2
2015	7	27	19	54	8	35	0	0	0	0	0	0	0	68.68	0	0	12.2
2015	7	27	20	4	8	35	0	0	0	0	0	0	0	68.7	0	0	12.2
2015	7	27	20	14	8	35	0	0	0	0	0	0	0	68.7	0	0	12.2
2015	7	27	20	24	8	35	0	0	0	0	0	0	0	68.74	0	0	12.2
2015	7	27	20	34	8	35	0	0	0	0	0	0	0	68.76	0	0	12.2
2015	7	27	20	44	8	34	0	0	0	0	0	0	0	68.77	0	0	12.2
2015	7	27	20	54	8	34	0	0	0	0	0	0	0	68.77	0	0	12.2
2015	7	27	21	4	8	34	0	0	0	0	0	0	0	68.79	0	0	12.2
2015	7	27	21	14	8	34	0	0	0	0	0	0	0	68.81	0	0	12.2
2015	7	27	21	24	8	35	0	0	0	0	0	0	0	68.83	0	0	12.2
2015	7	27	21	34	8	34	0	0	0	0	0	0	0	68.85	0	0	12.2
2015	7	27	21	44	8	34	0	0	0	0	0	0	0	68.86	0	0	12.2
2015	7	27	21	54	8	34	0	0	0	0	0	0	0	68.86	0	0	12.2
2015	7	27	22	4	8	35	0	0	0	0	0	0	0	68.88	0	0	12.2
2015	7	27	22	14	8	34	0	0	0	0	0	0	0	68.88	0	0	12.2
2015	7	27	22	24	8	34	0	0	0	0	0	0	0	68.9	0	0	12.2
2015	7	27	22	34	8	34	0	0	0	0	0	0	0	68.9	0	0	12
2015	7	27	22	44	8	34	0	0	0	0	0	0	0	68.9	0	0	12.2
2015	7	27	22	54	8	34	0	0	0	0	0	0	0	68.92	0	0	12.2
2015	7	27	23	4	8	34	0	0	0	0	0	0	0	68.92	0	0	12
2015	7	27	23	14	8	35	0	0	0	0	0	0	0	68.92	0	0	12
2015	7	27	23	24	8	34	0	0	0	0	0	0	0	68.92	0	0	12
2015	7	27	23	34	8	35	0	0	0	0	0	0	0	68.92	0	0	12
2015	7	27	23	44	8	35	0	0	0	0	0	0	0	68.92	0	0	12
2015	7	27	23	54	8	35	0	0	0	0	0	0	0	68.9	0	0	12
2015	7	28	0	4	8	35	0	0	0	0	0	0	0	68.9	0	0	12
2015	7	28	0	14	8	34	0	0	0	0	0	0	0	68.9	0	0	12
2015	7	28	0	24	8	34	0	0	0	0	0	0	0	68.9	0	0	12
2015	7	28	0	34	8	35	0	0	0	0	0	0	0	68.88	0	0	12
2015	7	28	0	44	8	34	0	0	0	0	0	0	0	68.88	0	0	12
2015	7	28	0	54	8	34	0	0	0	0	0	0	0	68.88	0	0	12
2015	7	28	1	4	8	35	0	0	0	0	0	0	0	68.86	0	0	12
2015	7	28	1	14	8	34	0	0	0	0	0	0	0	68.86	0	0	12
2015	7	28	1	24	8	34	0	0	0	0	0	0	0	68.85	0	0	12
2015	7	28	1	34	8	35	0	0	0	0	0	0	0	68.85	0	0	12
2015	7	28	1	44	8	35	0	0	0	0	0	0	0	68.83	0	0	12
2015	7	28	1	54	8	35	0	0	0	0	0	0	0	68.81	0	0	12
2015	7	28	2	4	8	35	0	0	0	0	0	0	0	68.79	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	28	2	14	8	34		0	0	0	0	0	0	68.79	0	0	12
2015	7	28	2	24	8	34		0	0	0	0	0	0	68.77	0	0	12
2015	7	28	2	34	8	35		0	0	0	0	0	0	68.76	0	0	12
2015	7	28	2	44	8	35		0	0	0	0	0	0	68.74	0	0	12
2015	7	28	2	54	8	34		0	0	0	0	0	0	68.72	0	0	12
2015	7	28	3	4	8	34		0	0	0	0	0	0	68.7	0	0	12
2015	7	28	3	14	8	35		0	0	0	0	0	0	68.68	0	0	12
2015	7	28	3	24	8	34		0	0	0	0	0	0	68.67	0	0	12
2015	7	28	3	34	8	35		0	0	0	0	0	0	68.63	0	0	12
2015	7	28	3	44	8	35		0	0	0	0	0	0	68.61	0	0	12
2015	7	28	3	54	8	35		0	0	0	0	0	0	68.59	0	0	12
2015	7	28	4	4	8	35		0	0	0	0	0	0	68.56	0	0	12
2015	7	28	4	14	8	34		0	0	0	0	0	0	68.52	0	0	12
2015	7	28	4	24	8	34		0	0	0	0	0	0	68.49	0	0	12
2015	7	28	4	34	8	34		0	0	0	0	0	0	68.47	0	0	12
2015	7	28	4	44	8	34		0	0	0	0	0	0	68.41	0	0	12
2015	7	28	4	54	8	35		0	0	0	0	0	0	68.38	0	0	12
2015	7	28	5	4	8	35		0	0	0	0	0	0	68.34	0	0	12
2015	7	28	5	14	8	35		0	0	0	0	0	0	68.31	0	0	12
2015	7	28	5	24	8	35		0	0	0	0	0	0	68.29	0	0	12
2015	7	28	5	34	8	35		0	0	0	0	0	0	68.23	0	0	12
2015	7	28	5	44	8	34		0	0	0	0	0	0	68.2	0	0	12
2015	7	28	5	54	8	35		0	0	0	0	0	0	68.16	0	0	12
2015	7	28	6	4	8	35		0	0	0	0	0	0	68.13	0	0	12
2015	7	28	6	14	8	35		0	0	0	0	0	0	68.09	0	0	12
2015	7	28	6	24	8	35		0	0	0	0	0	0	68.05	0	0	12
2015	7	28	6	34	8	34		0	0	0	0	0	0	68.04	0	0	12
2015	7	28	6	44	8	35		0	0	0	0	0	0	68	0	0	12
2015	7	28	6	54	8	35		0	0	0	0	0	0	67.98	0	0	12
2015	7	28	7	4	8	35		0	0	0	0	0	0	67.95	0	0	12.2
2015	7	28	7	14	8	34		0	0	0	0	0	0	67.93	0	0	12.2
2015	7	28	7	24	8	35		0	0	0	0	0	0	67.91	0	0	12.2
2015	7	28	7	34	8	34		0	0	0	0	0	0	67.89	0	0	12.4
2015	7	28	7	44	8	34		0	0	0	0	0	0	67.89	0	0	12.4
2015	7	28	7	54	8	36		0	0	0	0	0	0	67.87	0	0	12.6
2015	7	28	8	4	8	35		0	0	0	0	0	0	67.86	0	0	12.6
2015	7	28	8	14	8	34		0	0	0	0	0	0	67.86	0	0	12.6
2015	7	28	8	24	8	34		0	0	0	0	0	0	67.84	0	0	12.8
2015	7	28	8	34	8	35		0	0	0	0	0	0	67.86	0	0	12.8
2015	7	28	8	44	8	34		0	0	0	0	0	0	67.86	0	0	12.8
2015	7	28	8	54	8	35		0	0	0	0	0	0	67.86	0	0	12.8
2015	7	28	9	4	8	35		0	0	0	0	0	0	67.86	0	0	13
2015	7	28	9	14	8	35		0	0	0	0	0	0	67.87	0	0	13
2015	7	28	9	24	8	34		0	0	0	0	0	0	67.89	0	0	13.2
2015	7	28	9	34	8	35		0	0	0	0	0	0	67.89	0	0	13.4
2015	7	28	9	44	8	34		0	0	0	0	0	0	67.91	0	0	13.4
2015	7	28	9	54	8	35		0	0	0	0	0	0	67.93	0	0	13.4

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	28	10	4	8	35	0	0	0	0	0	0	0	67.95	0	0	13.4
2015	7	28	10	14	8	35	0	0	0	0	0	0	0	67.98	0	0	13.4
2015	7	28	10	24	8	35	0	0	0	0	0	0	0	68	0	0	13.2
2015	7	28	10	34	8	35	0	0	0	0	0	0	0	68.05	0	0	13.2
2015	7	28	10	44	8	35	0	0	0	0	0	0	0	68.07	0	0	13.2
2015	7	28	10	54	8	35	0	0	0	0	0	0	0	68.09	0	0	13.2
2015	7	28	11	4	8	35	0	0	0	0	0	0	0	68.13	0	0	13.2
2015	7	28	11	14	8	34	0	0	0	0	0	0	0	68.16	0	0	13.2
2015	7	28	11	24	8	36	0	0	0	0	0	0	0	68.2	0	0	13.2
2015	7	28	11	34	8	35	0	0	0	0	0	0	0	68.22	0	0	13.2
2015	7	28	11	44	8	35	0	0	0	0	0	0	0	68.25	0	0	13.2
2015	7	28	11	54	8	35	0	0	0	0	0	0	0	68.27	0	0	13.2
2015	7	28	12	4	8	34	0	0	0	0	0	0	0	68.31	0	0	13.2
2015	7	28	12	14	8	34	0	0	0	0	0	0	0	68.34	0	0	13.2
2015	7	28	12	24	8	35	0	0	0	0	0	0	0	68.38	0	0	13.2
2015	7	28	12	34	8	34	0	0	0	0	0	0	0	68.4	0	0	13.2
2015	7	28	12	44	8	35	0	0	0	0	0	0	0	68.43	0	0	13.2
2015	7	28	12	54	8	34	0	0	0	0	0	0	0	68.45	0	0	13.2
2015	7	28	13	4	8	35	0	0	0	0	0	0	0	68.47	0	0	13.2
2015	7	28	13	14	8	35	0	0	0	0	0	0	0	68.5	0	0	13.2
2015	7	28	13	24	8	35	0	0	0	0	0	0	0	68.54	0	0	13.2
2015	7	28	13	34	8	34	0	0	0	0	0	0	0	68.54	0	0	13.2
2015	7	28	13	44	8	34	0	0	0	0	0	0	0	68.54	0	0	13.2
2015	7	28	13	54	8	34	0	0	0	0	0	0	0	68.56	0	0	13.2
2015	7	28	14	4	8	35	0	0	0	0	0	0	0	68.56	0	0	13.2
2015	7	28	14	14	8	34	0	0	0	0	0	0	0	68.58	0	0	13.2
2015	7	28	14	24	8	35	0	0	0	0	0	0	0	68.56	0	0	13.2
2015	7	28	14	34	8	35	0	0	0	0	0	0	0	68.56	0	0	13.2
2015	7	28	14	44	8	35	0	0	0	0	0	0	0	68.56	0	0	13.2
2015	7	28	14	54	8	34	0	0	0	0	0	0	0	68.54	0	0	13
2015	7	28	15	4	8	35	0	0	0	0	0	0	0	68.54	0	0	13
2015	7	28	15	14	8	35	0	0	0	0	0	0	0	68.52	0	0	13
2015	7	28	15	24	8	34	0	0	0	0	0	0	0	68.52	0	0	13
2015	7	28	15	34	8	35	0	0	0	0	0	0	0	68.5	0	0	13
2015	7	28	15	44	8	34	0	0	0	0	0	0	0	68.49	0	0	13
2015	7	28	15	54	8	34	0	0	0	0	0	0	0	68.49	0	0	13
2015	7	28	16	4	8	35	0	0	0	0	0	0	0	68.47	0	0	13
2015	7	28	16	14	8	35	0	0	0	0	0	0	0	68.45	0	0	13
2015	7	28	16	24	8	35	0	0	0	0	0	0	0	68.43	0	0	13
2015	7	28	16	34	8	34	0	0	0	0	0	0	0	68.43	0	0	13
2015	7	28	16	44	8	34	0	0	0	0	0	0	0	68.41	0	0	13
2015	7	28	16	54	8	35	0	0	0	0	0	0	0	68.41	0	0	13
2015	7	28	17	4	8	34	0	0	0	0	0	0	0	68.4	0	0	13
2015	7	28	17	14	8	36	0	0	0	0	0	0	0	68.4	0	0	13
2015	7	28	17	24	8	35	0	0	0	0	0	0	0	68.38	0	0	13
2015	7	28	17	34	8	35	0	0	0	0	0	0	0	68.38	0	0	13
2015	7	28	17	44	8	34	0	0	0	0	0	0	0	68.36	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	28	17	54	8	35	0	0	0	0	0	0	0	68.36	0	0	13
2015	7	28	18	4	8	34	0	0	0	0	0	0	0	68.34	0	0	13
2015	7	28	18	14	8	34	0	0	0	0	0	0	0	68.36	0	0	13
2015	7	28	18	24	8	34	0	0	0	0	0	0	0	68.36	0	0	12.6
2015	7	28	18	34	8	34	0	0	0	0	0	0	0	68.4	0	0	12.2
2015	7	28	18	44	8	34	0	0	0	0	0	0	0	68.4	0	0	12.2
2015	7	28	18	54	8	35	0	0	0	0	0	0	0	68.41	0	0	12.2
2015	7	28	19	4	8	34	0	0	0	0	0	0	0	68.43	0	0	12.2
2015	7	28	19	14	8	35	0	0	0	0	0	0	0	68.45	0	0	12.2
2015	7	28	19	24	8	35	0	0	0	0	0	0	0	68.45	0	0	12.2
2015	7	28	19	34	8	35	0	0	0	0	0	0	0	68.49	0	0	12.2
2015	7	28	19	44	8	35	0	0	0	0	0	0	0	68.5	0	0	12.2
2015	7	28	19	54	8	34	0	0	0	0	0	0	0	68.52	0	0	12.2
2015	7	28	20	4	8	35	0	0	0	0	0	0	0	68.54	0	0	12.2
2015	7	28	20	14	8	34	0	0	0	0	0	0	0	68.56	0	0	12.2
2015	7	28	20	24	8	34	0	0	0	0	0	0	0	68.58	0	0	12.2
2015	7	28	20	34	8	35	0	0	0	0	0	0	0	68.59	0	0	12.2
2015	7	28	20	44	8	34	0	0	0	0	0	0	0	68.61	0	0	12.2
2015	7	28	20	54	8	35	0	0	0	0	0	0	0	68.63	0	0	12.2
2015	7	28	21	4	8	34	0	0	0	0	0	0	0	68.65	0	0	12.2
2015	7	28	21	14	8	34	0	0	0	0	0	0	0	68.67	0	0	12.2
2015	7	28	21	24	8	35	0	0	0	0	0	0	0	68.68	0	0	12.2
2015	7	28	21	34	8	34	0	0	0	0	0	0	0	68.7	0	0	12.2
2015	7	28	21	44	8	34	0	0	0	0	0	0	0	68.72	0	0	12.2
2015	7	28	21	54	8	35	0	0	0	0	0	0	0	68.74	0	0	12.2
2015	7	28	22	4	8	35	0	0	0	0	0	0	0	68.76	0	0	12.2
2015	7	28	22	14	8	34	0	0	0	0	0	0	0	68.76	0	0	12.2
2015	7	28	22	24	8	34	0	0	0	0	0	0	0	68.77	0	0	12.2
2015	7	28	22	34	8	35	0	0	0	0	0	0	0	68.79	0	0	12.2
2015	7	28	22	44	8	34	0	0	0	0	0	0	0	68.79	0	0	12.2
2015	7	28	22	54	8	35	0	0	0	0	0	0	0	68.79	0	0	12.2
2015	7	28	23	4	8	35	0	0	0	0	0	0	0	68.79	0	0	12
2015	7	28	23	14	8	35	0	0	0	0	0	0	0	68.79	0	0	12
2015	7	28	23	24	8	35	0	0	0	0	0	0	0	68.79	0	0	12
2015	7	28	23	34	8	34	0	0	0	0	0	0	0	68.81	0	0	12
2015	7	28	23	44	8	34	0	0	0	0	0	0	0	68.79	0	0	12
2015	7	28	23	54	8	35	0	0	0	0	0	0	0	68.79	0	0	12
2015	7	29	0	4	8	35	0	0	0	0	0	0	0	68.79	0	0	12
2015	7	29	0	14	8	35	0	0	0	0	0	0	0	68.79	0	0	12
2015	7	29	0	24	8	35	0	0	0	0	0	0	0	68.77	0	0	12
2015	7	29	0	34	8	35	0	0	0	0	0	0	0	68.76	0	0	12
2015	7	29	0	44	8	35	0	0	0	0	0	0	0	68.74	0	0	12
2015	7	29	0	54	8	34	0	0	0	0	0	0	0	68.72	0	0	12
2015	7	29	1	4	8	34	0	0	0	0	0	0	0	68.7	0	0	12
2015	7	29	1	14	8	35	0	0	0	0	0	0	0	68.67	0	0	12
2015	7	29	1	24	8	35	0	0	0	0	0	0	0	68.65	0	0	12
2015	7	29	1	34	8	34	0	0	0	0	0	0	0	68.61	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	29	1	44	8	35		0	0	0	0	0	0	68.58	0	0	12
2015	7	29	1	54	8	35		0	0	0	0	0	0	68.54	0	0	12
2015	7	29	2	4	8	34		0	0	0	0	0	0	68.52	0	0	12
2015	7	29	2	14	8	35		0	0	0	0	0	0	68.47	0	0	12
2015	7	29	2	24	8	35		0	0	0	0	0	0	68.41	0	0	12
2015	7	29	2	34	8	35		0	0	0	0	0	0	68.36	0	0	12
2015	7	29	2	44	8	35		0	0	0	0	0	0	68.32	0	0	12
2015	7	29	2	54	8	35		0	0	0	0	0	0	68.27	0	0	12
2015	7	29	3	4	8	35		0	0	0	0	0	0	68.23	0	0	12
2015	7	29	3	14	8	34		0	0	0	0	0	0	68.18	0	0	12
2015	7	29	3	24	8	34		0	0	0	0	0	0	68.13	0	0	12
2015	7	29	3	34	8	35		0	0	0	0	0	0	68.09	0	0	12
2015	7	29	3	44	8	35		0	0	0	0	0	0	68.04	0	0	12
2015	7	29	3	54	8	34		0	0	0	0	0	0	68	0	0	12
2015	7	29	4	4	8	35		0	0	0	0	0	0	67.95	0	0	12
2015	7	29	4	14	8	35		0	0	0	0	0	0	67.89	0	0	12
2015	7	29	4	24	8	35		0	0	0	0	0	0	67.86	0	0	12
2015	7	29	4	34	8	35		0	0	0	0	0	0	67.8	0	0	12
2015	7	29	4	44	8	35		0	0	0	0	0	0	67.75	0	0	12
2015	7	29	4	54	8	35		0	0	0	0	0	0	67.71	0	0	12
2015	7	29	5	4	8	34		0	0	0	0	0	0	67.66	0	0	12
2015	7	29	5	14	8	35		0	0	0	0	0	0	67.62	0	0	12
2015	7	29	5	24	8	35		0	0	0	0	0	0	67.59	0	0	12
2015	7	29	5	34	8	35		0	0	0	0	0	0	67.53	0	0	11.8
2015	7	29	5	44	8	35		0	0	0	0	0	0	67.48	0	0	12
2015	7	29	5	54	8	35		0	0	0	0	0	0	67.44	0	0	12
2015	7	29	6	4	8	35		0	0	0	0	0	0	67.41	0	0	12
2015	7	29	6	14	8	35		0	0	0	0	0	0	67.37	0	0	12
2015	7	29	6	24	8	35		0	0	0	0	0	0	67.33	0	0	12
2015	7	29	6	34	8	35		0	0	0	0	0	0	67.3	0	0	11.8
2015	7	29	6	44	8	35		0	0	0	0	0	0	67.26	0	0	12
2015	7	29	6	54	8	35		0	0	0	0	0	0	67.24	0	0	12
2015	7	29	7	4	8	35		0	0	0	0	0	0	67.21	0	0	12.2
2015	7	29	7	14	8	34		0	0	0	0	0	0	67.17	0	0	12.2
2015	7	29	7	24	8	35		0	0	0	0	0	0	67.15	0	0	12.2
2015	7	29	7	34	8	35		0	0	0	0	0	0	67.15	0	0	12.4
2015	7	29	7	44	8	35		0	0	0	0	0	0	67.17	0	0	12.6
2015	7	29	7	54	8	35		0	0	0	0	0	0	67.15	0	0	12.6
2015	7	29	8	4	8	34		0	0	0	0	0	0	67.17	0	0	12.8
2015	7	29	8	14	8	34		0	0	0	0	0	0	67.17	0	0	12.8
2015	7	29	8	24	8	35		0	0	0	0	0	0	67.19	0	0	12.8
2015	7	29	8	34	8	35		0	0	0	0	0	0	67.21	0	0	12.8
2015	7	29	8	44	8	35		0	0	0	0	0	0	67.23	0	0	12.8
2015	7	29	8	54	8	35		0	0	0	0	0	0	67.26	0	0	13
2015	7	29	9	4	8	35		0	0	0	0	0	0	67.26	0	0	13
2015	7	29	9	14	8	34		0	0	0	0	0	0	67.3	0	0	13.2
2015	7	29	9	24	8	35		0	0	0	0	0	0	67.33	0	0	13.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	29	9	34	8	35		0	0	0	0	0	0	67.37	0	0	13.2
2015	7	29	9	44	8	35		0	0	0	0	0	0	67.41	0	0	13.2
2015	7	29	9	54	8	34		0	0	0	0	0	0	67.46	0	0	13.2
2015	7	29	10	4	8	35		0	0	0	0	0	0	67.48	0	0	13.2
2015	7	29	10	14	8	35		0	0	0	0	0	0	67.55	0	0	13.2
2015	7	29	10	24	8	35		0	0	0	0	0	0	67.59	0	0	13.2
2015	7	29	10	34	8	34		0	0	0	0	0	0	67.62	0	0	13
2015	7	29	10	44	8	34		0	0	0	0	0	0	67.66	0	0	13
2015	7	29	10	54	8	35		0	0	0	0	0	0	67.69	0	0	13
2015	7	29	11	4	8	35		0	0	0	0	0	0	67.75	0	0	13
2015	7	29	11	14	8	34		0	0	0	0	0	0	67.8	0	0	13
2015	7	29	11	24	8	35		0	0	0	0	0	0	67.84	0	0	13
2015	7	29	11	34	8	35		0	0	0	0	0	0	67.87	0	0	13
2015	7	29	11	44	8	34		0	0	0	0	0	0	67.91	0	0	13
2015	7	29	11	54	8	35		0	0	0	0	0	0	67.96	0	0	13
2015	7	29	12	4	8	35		0	0	0	0	0	0	68	0	0	13
2015	7	29	12	14	8	35		0	0	0	0	0	0	68.04	0	0	13
2015	7	29	12	24	8	35		0	0	0	0	0	0	68.05	0	0	13
2015	7	29	12	34	8	35		0	0	0	0	0	0	68.11	0	0	13
2015	7	29	12	44	8	34		0	0	0	0	0	0	68.14	0	0	13
2015	7	29	12	54	8	35		0	0	0	0	0	0	68.16	0	0	13
2015	7	29	13	4	8	35		0	0	0	0	0	0	68.2	0	0	13
2015	7	29	13	14	8	35		0	0	0	0	0	0	68.22	0	0	13
2015	7	29	13	24	8	35		0	0	0	0	0	0	68.25	0	0	13
2015	7	29	13	34	8	35		0	0	0	0	0	0	68.23	0	0	13
2015	7	29	13	44	8	35		0	0	0	0	0	0	68.25	0	0	13
2015	7	29	13	54	8	35		0	0	0	0	0	0	68.29	0	0	13
2015	7	29	14	4	8	34		0	0	0	0	0	0	68.29	0	0	13
2015	7	29	14	14	8	35		0	0	0	0	0	0	68.29	0	0	13
2015	7	29	14	24	8	34		0	0	0	0	0	0	68.31	0	0	13
2015	7	29	14	34	8	35		0	0	0	0	0	0	68.31	0	0	13
2015	7	29	14	44	8	34		0	0	0	0	0	0	68.31	0	0	13
2015	7	29	14	54	8	34		0	0	0	0	0	0	68.29	0	0	13
2015	7	29	15	4	8	35		0	0	0	0	0	0	68.31	0	0	13
2015	7	29	15	14	8	35		0	0	0	0	0	0	68.29	0	0	13
2015	7	29	15	24	8	35		0	0	0	0	0	0	68.27	0	0	13
2015	7	29	15	34	8	34		0	0	0	0	0	0	68.29	0	0	13
2015	7	29	15	44	8	35		0	0	0	0	0	0	68.29	0	0	13
2015	7	29	15	54	8	35		0	0	0	0	0	0	68.27	0	0	13
2015	7	29	16	4	8	35		0	0	0	0	0	0	68.25	0	0	13
2015	7	29	16	14	8	35		0	0	0	0	0	0	68.23	0	0	13
2015	7	29	16	24	8	35		0	0	0	0	0	0	68.22	0	0	13
2015	7	29	16	34	8	35		0	0	0	0	0	0	68.22	0	0	13
2015	7	29	16	44	8	35		0	0	0	0	0	0	68.14	0	0	13
2015	7	29	16	54	8	35		0	0	0	0	0	0	68.14	0	0	13
2015	7	29	17	4	8	34		0	0	0	0	0	0	68.11	0	0	13
2015	7	29	17	14	8	34		0	0	0	0	0	0	68.14	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	29	17	24	8	35		0	0	0	0	0	0	68.13	0	0	13
2015	7	29	17	34	8	35		0	0	0	0	0	0	68.13	0	0	12.8
2015	7	29	17	44	8	35		0	0	0	0	0	0	68.13	0	0	13
2015	7	29	17	54	8	35		0	0	0	0	0	0	68.09	0	0	13
2015	7	29	18	4	8	35		0	0	0	0	0	0	68.11	0	0	12.4
2015	7	29	18	14	8	34		0	0	0	0	0	0	68.11	0	0	13
2015	7	29	18	24	8	35		0	0	0	0	0	0	68.11	0	0	12.4
2015	7	29	18	34	8	35		0	0	0	0	0	0	68.13	0	0	12.2
2015	7	29	18	44	8	35		0	0	0	0	0	0	68.14	0	0	12.2
2015	7	29	18	54	8	34		0	0	0	0	0	0	68.14	0	0	12.2
2015	7	29	19	4	8	35		0	0	0	0	0	0	68.16	0	0	12.2
2015	7	29	19	14	8	34		0	0	0	0	0	0	68.18	0	0	12.2
2015	7	29	19	24	8	35		0	0	0	0	0	0	68.2	0	0	12.2
2015	7	29	19	34	8	35		0	0	0	0	0	0	68.22	0	0	12.2
2015	7	29	19	44	8	35		0	0	0	0	0	0	68.25	0	0	12.2
2015	7	29	19	54	8	35		0	0	0	0	0	0	68.29	0	0	12.2
2015	7	29	20	4	8	35		0	0	0	0	0	0	68.32	0	0	12.2
2015	7	29	20	14	8	35		0	0	0	0	0	0	68.34	0	0	12.2
2015	7	29	20	24	8	35		0	0	0	0	0	0	68.38	0	0	12.2
2015	7	29	20	34	8	34		0	0	0	0	0	0	68.41	0	0	12.2
2015	7	29	20	44	8	35		0	0	0	0	0	0	68.45	0	0	12.2
2015	7	29	20	54	8	35		0	0	0	0	0	0	68.47	0	0	12.2
2015	7	29	21	4	8	34		0	0	0	0	0	0	68.5	0	0	12.2
2015	7	29	21	14	8	35		0	0	0	0	0	0	68.52	0	0	12.2
2015	7	29	21	24	8	35		0	0	0	0	0	0	68.56	0	0	12.2
2015	7	29	21	34	8	35		0	0	0	0	0	0	68.58	0	0	12.2
2015	7	29	21	44	8	35		0	0	0	0	0	0	68.61	0	0	12.2
2015	7	29	21	54	8	34		0	0	0	0	0	0	68.65	0	0	12.2
2015	7	29	22	4	8	34		0	0	0	0	0	0	68.67	0	0	12.2
2015	7	29	22	14	8	34		0	0	0	0	0	0	68.7	0	0	12.2
2015	7	29	22	24	8	34		0	0	0	0	0	0	68.74	0	0	12.2
2015	7	29	22	34	8	35		0	0	0	0	0	0	68.77	0	0	12
2015	7	29	22	44	8	35		0	0	0	0	0	0	68.81	0	0	12.2
2015	7	29	22	54	8	35		0	0	0	0	0	0	68.83	0	0	12.2
2015	7	29	23	4	8	36		0	0	0	0	0	0	68.86	0	0	12.2
2015	7	29	23	14	8	35		0	0	0	0	0	0	68.88	0	0	12.2
2015	7	29	23	24	8	35		0	0	0	0	0	0	68.92	0	0	12.2
2015	7	29	23	34	8	35		0	0	0	0	0	0	68.94	0	0	12
2015	7	29	23	44	8	35		0	0	0	0	0	0	68.95	0	0	12.2
2015	7	29	23	54	8	34		0	0	0	0	0	0	68.99	0	0	12
2015	7	30	0	4	8	34		0	0	0	0	0	0	69.03	0	0	12
2015	7	30	0	14	8	35		0	0	0	0	0	0	69.03	0	0	12
2015	7	30	0	24	8	35		0	0	0	0	0	0	69.06	0	0	12
2015	7	30	0	34	8	35		0	0	0	0	0	0	69.08	0	0	12
2015	7	30	0	44	8	34		0	0	0	0	0	0	69.1	0	0	12
2015	7	30	0	54	8	35		0	0	0	0	0	0	69.12	0	0	12
2015	7	30	1	4	8	34		0	0	0	0	0	0	69.12	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	30	1	14	8	34	0	0	0	0	0	0	0	69.13	0	0	12
2015	7	30	1	24	8	35	0	0	0	0	0	0	0	69.15	0	0	12
2015	7	30	1	34	8	34	0	0	0	0	0	0	0	69.15	0	0	12
2015	7	30	1	44	8	35	0	0	0	0	0	0	0	69.15	0	0	12
2015	7	30	1	54	8	35	0	0	0	0	0	0	0	69.15	0	0	12
2015	7	30	2	4	8	34	0	0	0	0	0	0	0	69.15	0	0	12
2015	7	30	2	14	8	35	0	0	0	0	0	0	0	69.13	0	0	12
2015	7	30	2	24	8	34	0	0	0	0	0	0	0	69.13	0	0	12
2015	7	30	2	34	8	35	0	0	0	0	0	0	0	69.12	0	0	12
2015	7	30	2	44	8	34	0	0	0	0	0	0	0	69.1	0	0	12
2015	7	30	2	54	8	35	0	0	0	0	0	0	0	69.1	0	0	12
2015	7	30	3	4	8	34	0	0	0	0	0	0	0	69.08	0	0	12
2015	7	30	3	14	8	35	0	0	0	0	0	0	0	69.06	0	0	12
2015	7	30	3	24	8	35	0	0	0	0	0	0	0	69.03	0	0	12
2015	7	30	3	34	8	34	0	0	0	0	0	0	0	69.01	0	0	12
2015	7	30	3	44	8	34	0	0	0	0	0	0	0	68.99	0	0	12
2015	7	30	3	54	8	35	0	0	0	0	0	0	0	68.97	0	0	12
2015	7	30	4	4	8	35	0	0	0	0	0	0	0	68.94	0	0	12
2015	7	30	4	14	8	34	0	0	0	0	0	0	0	68.9	0	0	12
2015	7	30	4	24	8	35	0	0	0	0	0	0	0	68.88	0	0	12
2015	7	30	4	34	8	34	0	0	0	0	0	0	0	68.85	0	0	12
2015	7	30	4	44	8	35	0	0	0	0	0	0	0	68.81	0	0	12
2015	7	30	4	54	8	35	0	0	0	0	0	0	0	68.79	0	0	12
2015	7	30	5	4	8	35	0	0	0	0	0	0	0	68.76	0	0	12
2015	7	30	5	14	8	35	0	0	0	0	0	0	0	68.72	0	0	12
2015	7	30	5	24	8	35	0	0	0	0	0	0	0	68.7	0	0	12
2015	7	30	5	34	8	35	0	0	0	0	0	0	0	68.67	0	0	12
2015	7	30	5	44	8	35	0	0	0	0	0	0	0	68.63	0	0	12
2015	7	30	5	54	8	34	0	0	0	0	0	0	0	68.61	0	0	12
2015	7	30	6	4	8	34	0	0	0	0	0	0	0	68.58	0	0	12
2015	7	30	6	14	8	35	0	0	0	0	0	0	0	68.54	0	0	12
2015	7	30	6	24	8	35	0	0	0	0	0	0	0	68.52	0	0	12
2015	7	30	6	34	8	35	0	0	0	0	0	0	0	68.49	0	0	12
2015	7	30	6	44	8	34	0	0	0	0	0	0	0	68.47	0	0	12
2015	7	30	6	54	8	35	0	0	0	0	0	0	0	68.45	0	0	12
2015	7	30	7	4	8	35	0	0	0	0	0	0	0	68.41	0	0	12.2
2015	7	30	7	14	8	34	0	0	0	0	0	0	0	68.4	0	0	12.2
2015	7	30	7	24	8	35	0	0	0	0	0	0	0	68.38	0	0	12
2015	7	30	7	34	8	35	0	0	0	0	0	0	0	68.4	0	0	12.2
2015	7	30	7	44	8	35	0	0	0	0	0	0	0	68.4	0	0	12.2
2015	7	30	7	54	8	35	0	0	0	0	0	0	0	68.38	0	0	12.2
2015	7	30	8	4	8	36	0	0	0	0	0	0	0	68.38	0	0	12.2
2015	7	30	8	14	8	34	0	0	0	0	0	0	0	68.36	0	0	12.2
2015	7	30	8	24	8	34	0	0	0	0	0	0	0	68.38	0	0	12.2
2015	7	30	8	34	8	35	0	0	0	0	0	0	0	68.4	0	0	12.4
2015	7	30	8	44	8	34	0	0	0	0	0	0	0	68.43	0	0	12.6
2015	7	30	8	54	8	34	0	0	0	0	0	0	0	68.45	0	0	12.6

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	30	9	10	21	34		0	0	0	0	0	0	68.47	0	0	12.8
2015	7	30	9	20	21	34		0	0	0	0	0	0	68.58	0	0	12.8
2015	7	30	9	30	21	35		0	0	0	0	0	0	68.58	0	0	12.8
2015	7	30	9	40	21	34		0	0	0	0	0	0	68.49	0	0	12.6
2015	7	30	9	50	21	35		0	0	0	0	0	0	68.49	0	0	12.6
2015	7	30	10	0	21	35		0	0	0	0	0	0	68.49	0	0	12.6
2015	7	30	10	10	21	35		0	0	0	0	0	0	68.5	0	0	12.6
2015	7	30	10	20	21	35		0	0	0	0	0	0	68.5	0	0	12.6
2015	7	30	10	30	21	35		0	0	0	0	0	0	68.56	0	0	12.8
2015	7	30	10	40	21	34		0	0	0	0	0	0	68.61	0	0	12.8
2015	7	30	10	50	21	34		0	0	0	0	0	0	68.72	0	0	13.2
2015	7	30	11	0	21	35		0	0	0	0	0	0	68.72	0	0	13
2015	7	30	11	10	21	34		0	0	0	0	0	0	68.76	0	0	13.2
2015	7	30	11	20	21	34		0	0	0	0	0	0	68.7	0	0	13.2
2015	7	30	11	30	21	35		0	0	0	0	0	0	68.67	0	0	13
2015	7	30	11	40	21	35		0	0	0	0	0	0	68.67	0	0	13.2
2015	7	30	11	50	21	35		0	0	0	0	0	0	68.68	0	0	13.2
2015	7	30	12	0	21	35		0	0	0	0	0	0	68.76	0	0	13.2
2015	7	30	12	10	21	35		0	0	0	0	0	0	68.74	0	0	13.2
2015	7	30	12	20	21	34		0	0	0	0	0	0	68.76	0	0	13.2
2015	7	30	12	30	21	35		0	0	0	0	0	0	68.83	0	0	13.2
2015	7	30	12	40	21	35		0	0	0	0	0	0	68.77	0	0	13.2
2015	7	30	12	50	21	35		0	0	0	0	0	0	68.74	0	0	13.2
2015	7	30	13	0	21	35		0	0	0	0	0	0	68.76	0	0	13.2
2015	7	30	13	10	21	35		0	0	0	0	0	0	68.81	0	0	13.2
2015	7	30	13	20	21	35		0	0	0	0	0	0	69.01	0	0	13.2
2015	7	30	13	30	21	35		0	0	0	0	0	0	68.97	0	0	13.2
2015	7	30	13	40	21	34		0	0	0	0	0	0	68.94	0	0	13.2
2015	7	30	13	50	21	35		0	0	0	0	0	0	68.86	0	0	13.2
2015	7	30	14	0	21	34		0	0	0	0	0	0	68.83	0	0	13.2
2015	7	30	14	10	21	35		0	0	0	0	0	0	68.86	0	0	13.2
2015	7	30	14	20	21	35		0	0	0	0	0	0	68.97	0	0	13.2
2015	7	30	14	30	21	35		0	0	0	0	0	0	68.97	0	0	13.2
2015	7	30	14	40	21	35		0	0	0	0	0	0	69.04	0	0	13.2
2015	7	30	14	50	21	34		0	0	0	0	0	0	69.08	0	0	13.2
2015	7	30	15	0	21	34		0	0	0	0	0	0	69.08	0	0	13
2015	7	30	15	10	21	34		0	0	0	0	0	0	69.15	0	0	13
2015	7	30	15	20	21	35		0	0	0	0	0	0	69.3	0	0	13
2015	7	30	15	30	21	34		0	0	0	0	0	0	69.15	0	0	13
2015	7	30	15	40	21	34		0	0	0	0	0	0	69.01	0	0	13
2015	7	30	15	50	21	35		0	0	0	0	0	0	68.92	0	0	12.4
2015	7	30	16	0	21	35		0	0	0	0	0	0	68.85	0	0	12.2
2015	7	30	16	10	21	35		0	0	0	0	0	0	68.83	0	0	12.4
2015	7	30	16	20	21	35		0	0	0	0	0	0	68.85	0	0	13.4
2015	7	30	16	30	21	34		0	0	0	0	0	0	68.83	0	0	12.8
2015	7	30	16	40	21	34		0	0	0	0	0	0	68.81	0	0	12.2
2015	7	30	16	50	21	34		0	0	0	0	0	0	68.79	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	30	17	0	21	35		0	0	0	0	0	0	68.79	0	0	12.2
2015	7	30	17	10	21	35		0	0	0	0	0	0	68.79	0	0	12.2
2015	7	30	17	20	21	35		0	0	0	0	0	0	68.79	0	0	12.2
2015	7	30	17	30	21	34		0	0	0	0	0	0	68.79	0	0	12.2
2015	7	30	17	40	21	35		0	0	0	0	0	0	68.79	0	0	12.2
2015	7	30	17	50	21	34		0	0	0	0	0	0	68.79	0	0	12.2
2015	7	30	18	0	21	35		0	0	0	0	0	0	68.79	0	0	12.2
2015	7	30	18	10	21	35		0	0	0	0	0	0	68.79	0	0	12.2
2015	7	30	18	20	21	34		0	0	0	0	0	0	68.79	0	0	12.2
2015	7	30	18	30	21	35		0	0	0	0	0	0	68.79	0	0	12.2
2015	7	30	18	40	21	35		0	0	0	0	0	0	68.81	0	0	12.2
2015	7	30	18	50	21	35		0	0	0	0	0	0	68.81	0	0	12.2
2015	7	30	19	0	21	35		0	0	0	0	0	0	68.81	0	0	12.2
2015	7	30	19	10	21	35		0	0	0	0	0	0	68.83	0	0	12.2
2015	7	30	19	20	21	34		0	0	0	0	0	0	68.83	0	0	12.2
2015	7	30	19	30	21	35		0	0	0	0	0	0	68.83	0	0	12.2
2015	7	30	19	40	21	34		0	0	0	0	0	0	68.83	0	0	12.2
2015	7	30	19	50	21	35		0	0	0	0	0	0	68.85	0	0	12.2
2015	7	30	20	0	21	35		0	0	0	0	0	0	68.85	0	0	12.2
2015	7	30	20	10	21	35		0	0	0	0	0	0	68.85	0	0	12.2
2015	7	30	20	20	21	35		0	0	0	0	0	0	68.86	0	0	12.2
2015	7	30	20	30	21	34		0	0	0	0	0	0	68.86	0	0	12.2
2015	7	30	20	40	21	34		0	0	0	0	0	0	68.86	0	0	12.2
2015	7	30	20	50	21	34		0	0	0	0	0	0	68.9	0	0	12.2
2015	7	30	21	0	21	35		0	0	0	0	0	0	68.9	0	0	12.2
2015	7	30	21	10	21	35		0	0	0	0	0	0	68.92	0	0	12.2
2015	7	30	21	20	21	34		0	0	0	0	0	0	68.94	0	0	12.2
2015	7	30	21	30	21	34		0	0	0	0	0	0	68.94	0	0	12.2
2015	7	30	21	40	21	34		0	0	0	0	0	0	68.95	0	0	12.2
2015	7	30	21	50	21	35		0	0	0	0	0	0	68.97	0	0	12
2015	7	30	22	0	21	35		0	0	0	0	0	0	68.97	0	0	12
2015	7	30	22	10	21	35		0	0	0	0	0	0	68.99	0	0	12
2015	7	30	22	20	21	35		0	0	0	0	0	0	69.01	0	0	12
2015	7	30	22	30	21	35		0	0	0	0	0	0	69.01	0	0	12
2015	7	30	22	40	21	34		0	0	0	0	0	0	69.03	0	0	12
2015	7	30	22	50	21	34		0	0	0	0	0	0	69.04	0	0	12
2015	7	30	23	0	21	34		0	0	0	0	0	0	69.06	0	0	12
2015	7	30	23	10	21	35		0	0	0	0	0	0	69.06	0	0	12
2015	7	30	23	20	21	34		0	0	0	0	0	0	69.08	0	0	12
2015	7	30	23	30	21	35		0	0	0	0	0	0	69.08	0	0	12
2015	7	30	23	40	21	35		0	0	0	0	0	0	69.08	0	0	12
2015	7	30	23	50	21	35		0	0	0	0	0	0	69.08	0	0	12
2015	7	31	0	0	21	34		0	0	0	0	0	0	69.1	0	0	12
2015	7	31	0	10	21	34		0	0	0	0	0	0	69.1	0	0	12
2015	7	31	0	20	21	34		0	0	0	0	0	0	69.1	0	0	12
2015	7	31	0	30	21	34		0	0	0	0	0	0	69.1	0	0	12
2015	7	31	0	40	21	36		0	0	0	0	0	0	69.1	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	31	0	50	21	35		0	0	0	0	0	0	69.1	0	0	12
2015	7	31	1	0	21	35		0	0	0	0	0	0	69.1	0	0	12
2015	7	31	1	10	21	35		0	0	0	0	0	0	69.08	0	0	12
2015	7	31	1	20	21	34		0	0	0	0	0	0	69.08	0	0	12
2015	7	31	1	30	21	34		0	0	0	0	0	0	69.08	0	0	12
2015	7	31	1	40	21	34		0	0	0	0	0	0	69.08	0	0	12
2015	7	31	1	50	21	34		0	0	0	0	0	0	69.06	0	0	12
2015	7	31	2	0	21	34		0	0	0	0	0	0	69.06	0	0	12
2015	7	31	2	10	21	34		0	0	0	0	0	0	69.04	0	0	12
2015	7	31	2	20	21	35		0	0	0	0	0	0	69.03	0	0	12
2015	7	31	2	30	21	34		0	0	0	0	0	0	69.03	0	0	12
2015	7	31	2	40	21	34		0	0	0	0	0	0	69.03	0	0	12
2015	7	31	2	50	21	35		0	0	0	0	0	0	69.01	0	0	12
2015	7	31	3	0	21	34		0	0	0	0	0	0	68.99	0	0	12
2015	7	31	3	10	21	35		0	0	0	0	0	0	68.99	0	0	12
2015	7	31	3	20	21	34		0	0	0	0	0	0	68.99	0	0	12
2015	7	31	3	30	21	34		0	0	0	0	0	0	68.97	0	0	12
2015	7	31	3	40	21	34		0	0	0	0	0	0	68.97	0	0	12
2015	7	31	3	50	21	35		0	0	0	0	0	0	68.95	0	0	12
2015	7	31	4	0	21	34		0	0	0	0	0	0	68.95	0	0	12
2015	7	31	4	10	21	34		0	0	0	0	0	0	68.95	0	0	12
2015	7	31	4	20	21	35		0	0	0	0	0	0	68.95	0	0	12
2015	7	31	4	30	21	34		0	0	0	0	0	0	68.95	0	0	12
2015	7	31	4	40	21	35		0	0	0	0	0	0	68.94	0	0	12
2015	7	31	4	50	21	35		0	0	0	0	0	0	68.94	0	0	12
2015	7	31	5	0	21	35		0	0	0	0	0	0	68.94	0	0	12
2015	7	31	5	10	21	35		0	0	0	0	0	0	68.94	0	0	12
2015	7	31	5	20	21	34		0	0	0	0	0	0	68.94	0	0	12
2015	7	31	5	30	21	35		0	0	0	0	0	0	68.94	0	0	12
2015	7	31	5	40	21	35		0	0	0	0	0	0	68.94	0	0	12
2015	7	31	5	50	21	35		0	0	0	0	0	0	68.94	0	0	12
2015	7	31	6	0	21	34		0	0	0	0	0	0	68.94	0	0	12
2015	7	31	6	10	21	34		0	0	0	0	0	0	68.94	0	0	12
2015	7	31	6	20	21	35		0	0	0	0	0	0	68.94	0	0	12
2015	7	31	6	30	21	35		0	0	0	0	0	0	68.92	0	0	12
2015	7	31	6	40	21	35		0	0	0	0	0	0	68.94	0	0	12
2015	7	31	6	50	21	35		0	0	0	0	0	0	68.92	0	0	12
2015	7	31	7	0	21	34		0	0	0	0	0	0	68.92	0	0	12
2015	7	31	7	10	21	35		0	0	0	0	0	0	68.92	0	0	12
2015	7	31	7	20	21	35		0	0	0	0	0	0	68.92	0	0	12
2015	7	31	7	30	21	35		0	0	0	0	0	0	68.92	0	0	12
2015	7	31	7	40	21	35		0	0	0	0	0	0	68.92	0	0	12
2015	7	31	7	50	21	34		0	0	0	0	0	0	68.92	0	0	12
2015	7	31	8	0	21	35		0	0	0	0	0	0	68.92	0	0	12
2015	7	31	8	10	21	34		0	0	0	0	0	0	68.94	0	0	12
2015	7	31	8	20	21	36		0	0	0	0	0	0	68.94	0	0	12
2015	7	31	8	30	21	35		0	0	0	0	0	0	68.94	0	0	12

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	31	8	40	21	35		0	0	0	0	0	0	68.94	0	0	12
2015	7	31	8	50	21	35		0	0	0	0	0	0	68.95	0	0	12
2015	7	31	9	0	21	36		0	0	0	0	0	0	68.95	0	0	12
2015	7	31	9	10	21	35		0	0	0	0	0	0	68.97	0	0	12
2015	7	31	9	20	21	35		0	0	0	0	0	0	68.99	0	0	12.2
2015	7	31	9	30	21	34		0	0	0	0	0	0	68.99	0	0	12.2
2015	7	31	9	40	21	34		0	0	0	0	0	0	69.01	0	0	12.2
2015	7	31	9	50	21	35		0	0	0	0	0	0	69.03	0	0	12.2
2015	7	31	10	0	21	34		0	0	0	0	0	0	69.04	0	0	12.4
2015	7	31	10	10	21	35		0	0	0	0	0	0	69.08	0	0	12.6
2015	7	31	10	20	21	35		0	0	0	0	0	0	69.08	0	0	12.6
2015	7	31	10	30	21	35		0	0	0	0	0	0	69.1	0	0	12.6
2015	7	31	10	40	21	34		0	0	0	0	0	0	69.13	0	0	12.6
2015	7	31	10	50	21	35		0	0	0	0	0	0	69.13	0	0	12.6
2015	7	31	11	0	21	34		0	0	0	0	0	0	69.13	0	0	12.6
2015	7	31	11	10	21	34		0	0	0	0	0	0	69.13	0	0	12.6
2015	7	31	11	20	21	34		0	0	0	0	0	0	69.15	0	0	12.6
2015	7	31	11	30	21	35		0	0	0	0	0	0	69.19	0	0	12.6
2015	7	31	11	40	21	35		0	0	0	0	0	0	69.21	0	0	12.6
2015	7	31	11	50	21	35		0	0	0	0	0	0	69.24	0	0	12.6
2015	7	31	12	0	21	34		0	0	0	0	0	0	69.26	0	0	12.6
2015	7	31	12	10	21	35		0	0	0	0	0	0	69.31	0	0	12.8
2015	7	31	12	20	21	35		0	0	0	0	0	0	69.37	0	0	12.8
2015	7	31	12	30	21	35		0	0	0	0	0	0	69.37	0	0	12.8
2015	7	31	12	40	21	34		0	0	0	0	0	0	69.35	0	0	12.8
2015	7	31	12	50	21	35		0	0	0	0	0	0	69.33	0	0	12.8
2015	7	31	13	0	21	35		0	0	0	0	0	0	69.4	0	0	12.8
2015	7	31	13	10	21	35		0	0	0	0	0	0	69.4	0	0	12.8
2015	7	31	13	20	21	35		0	0	0	0	0	0	69.37	0	0	12.8
2015	7	31	13	30	21	34		0	0	0	0	0	0	69.55	0	0	13
2015	7	31	13	40	21	34		0	0	0	0	0	0	69.48	0	0	13
2015	7	31	13	50	21	34		0	0	0	0	0	0	69.48	0	0	13.2
2015	7	31	14	0	21	35		0	0	0	0	0	0	69.64	0	0	13.2
2015	7	31	14	10	21	35		0	0	0	0	0	0	69.71	0	0	13.2
2015	7	31	14	20	21	35		0	0	0	0	0	0	69.84	0	0	13.2
2015	7	31	14	30	21	35		0	0	0	0	0	0	69.87	0	0	13.2
2015	7	31	14	40	21	35		0	0	0	0	0	0	69.89	0	0	13.2
2015	7	31	14	50	21	34		0	0	0	0	0	0	69.85	0	0	13
2015	7	31	15	0	21	35		0	0	0	0	0	0	69.93	0	0	13
2015	7	31	15	10	21	35		0	0	0	0	0	0	69.94	0	0	13
2015	7	31	15	20	21	34		0	0	0	0	0	0	69.94	0	0	13
2015	7	31	15	30	21	35		0	0	0	0	0	0	69.93	0	0	13
2015	7	31	15	40	21	34		0	0	0	0	0	0	69.93	0	0	13
2015	7	31	15	50	21	35		0	0	0	0	0	0	69.93	0	0	13
2015	7	31	16	0	21	34		0	0	0	0	0	0	69.91	0	0	13
2015	7	31	16	10	21	34		0	0	0	0	0	0	69.89	0	0	13
2015	7	31	16	20	21	34		0	0	0	0	0	0	69.85	0	0	13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	31	16	30	21	35		0	0	0	0	0	0	69.87	0	0	13
2015	7	31	16	40	21	34		0	0	0	0	0	0	69.85	0	0	13
2015	7	31	16	50	21	35		0	0	0	0	0	0	69.85	0	0	13
2015	7	31	17	0	21	34		0	0	0	0	0	0	69.76	0	0	13
2015	7	31	17	10	21	35		0	0	0	0	0	0	69.71	0	0	13
2015	7	31	17	20	21	35		0	0	0	0	0	0	69.73	0	0	13
2015	7	31	17	30	21	34		0	0	0	0	0	0	69.73	0	0	13
2015	7	31	17	40	21	34		0	0	0	0	0	0	69.73	0	0	13.2
2015	7	31	17	50	21	34		0	0	0	0	0	0	69.73	0	0	13.2
2015	7	31	18	0	21	34		0	0	0	0	0	0	69.71	0	0	13.2
2015	7	31	18	10	21	34		0	0	0	0	0	0	69.71	0	0	13.2
2015	7	31	18	20	21	35		0	0	0	0	0	0	69.71	0	0	13.2
2015	7	31	18	30	21	35		0	0	0	0	0	0	69.73	0	0	12.8
2015	7	31	18	40	21	34		0	0	0	0	0	0	69.73	0	0	12.4
2015	7	31	18	50	21	35		0	0	0	0	0	0	69.73	0	0	12.2
2015	7	31	19	0	21	34		0	0	0	0	0	0	69.73	0	0	12.2
2015	7	31	19	10	21	35		0	0	0	0	0	0	69.73	0	0	12.2
2015	7	31	19	20	21	35		0	0	0	0	0	0	69.73	0	0	12.2
2015	7	31	19	30	21	34		0	0	0	0	0	0	69.75	0	0	12.2
2015	7	31	19	40	21	34		0	0	0	0	0	0	69.75	0	0	12.2
2015	7	31	19	50	21	35		0	0	0	0	0	0	69.76	0	0	12.2
2015	7	31	20	0	21	35		0	0	0	0	0	0	69.78	0	0	12.2
2015	7	31	20	10	21	34		0	0	0	0	0	0	69.8	0	0	12.2
2015	7	31	20	20	21	35		0	0	0	0	0	0	69.8	0	0	12.2
2015	7	31	20	30	21	34		0	0	0	0	0	0	69.82	0	0	12.2
2015	7	31	20	40	21	35		0	0	0	0	0	0	69.82	0	0	12.2
2015	7	31	20	50	21	34		0	0	0	0	0	0	69.84	0	0	12.2
2015	7	31	21	0	21	35		0	0	0	0	0	0	69.85	0	0	12.2
2015	7	31	21	10	21	34		0	0	0	0	0	0	69.87	0	0	12.2
2015	7	31	21	20	21	34		0	0	0	0	0	0	69.87	0	0	12.2
2015	7	31	21	30	21	34		0	0	0	0	0	0	69.89	0	0	12.2
2015	7	31	21	40	21	35		0	0	0	0	0	0	69.93	0	0	12.2
2015	7	31	21	50	21	34		0	0	0	0	0	0	69.93	0	0	12.2
2015	7	31	22	0	21	35		0	0	0	0	0	0	69.94	0	0	12.2
2015	7	31	22	10	21	35		0	0	0	0	0	0	69.96	0	0	12.2
2015	7	31	22	20	21	34		0	0	0	0	0	0	70	0	0	12.2
2015	7	31	22	30	21	34		0	0	0	0	0	0	70.02	0	0	12.2
2015	7	31	22	40	21	35		0	0	0	0	0	0	70.02	0	0	12.2
2015	7	31	22	50	21	34		0	0	0	0	0	0	70.03	0	0	12.2
2015	7	31	23	0	21	34		0	0	0	0	0	0	70.07	0	0	12.2
2015	7	31	23	10	21	34		0	0	0	0	0	0	70.09	0	0	12.2
2015	7	31	23	20	21	34		0	0	0	0	0	0	70.09	0	0	12.2
2015	7	31	23	30	21	34		0	0	0	0	0	0	70.11	0	0	12.2
2015	7	31	23	40	21	35		0	0	0	0	0	0	70.12	0	0	12.2
2015	7	31	23	50	21	34		0	0	0	0	0	0	70.14	0	0	12.2

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	1	0	4	8	0.3	3.9	0.67	94.5	83.8845	52.8508
2015	7	1	0	14	8	0.3	3.9	0.71	95.9	83.8845	55.7147
2015	7	1	0	24	8	0.3	3.9	0.67	98.2	83.8845	52.3301
2015	7	1	0	34	8	0.3	3.9	0.69	97.1	83.9501	54.4571
2015	7	1	0	44	8	0.3	3.9	0.64	97.6	83.9501	50.5487
2015	7	1	0	54	8	0.3	3.9	0.69	95.7	83.9501	54.7177
2015	7	1	1	4	8	0.3	3.9	0.67	96.2	83.9501	53.1543
2015	7	1	1	14	8	0.3	3.9	0.64	97.9	83.9501	50.5487
2015	7	1	1	24	8	0.3	3.9	0.66	94.5	84.0158	52.6759
2015	7	1	1	34	8	0.3	3.9	0.66	96.9	84.0158	51.8936
2015	7	1	1	44	8	0.3	3.9	0.7	96.5	84.0158	55.0229
2015	7	1	1	54	8	0.3	3.9	0.69	96	84.0158	54.5013
2015	7	1	2	4	8	0.3	3.9	0.7	97.5	84.0158	55.2837
2015	7	1	2	14	8	0.3	3.9	0.66	97.7	84.0158	51.8936
2015	7	1	2	24	8	0.3	3.9	0.7	96.2	84.0158	55.2837
2015	7	1	2	34	8	0.3	3.9	0.69	95.5	84.0158	54.2406
2015	7	1	2	44	8	0.3	3.9	0.65	97.8	84.0814	51.4138
2015	7	1	2	54	8	0.3	3.9	0.7	95.7	84.0814	55.0675
2015	7	1	3	4	8	0.3	3.9	0.68	93.6	84.0814	54.0236
2015	7	1	3	14	8	0.3	3.9	0.68	96.3	84.0814	54.0236
2015	7	1	3	24	8	0.3	3.9	0.7	97.5	84.0814	55.3285
2015	7	1	3	34	8	0.3	3.9	0.63	97.1	84.0814	50.1089
2015	7	1	3	44	8	0.3	3.9	0.72	99.7	84.0814	56.3725
2015	7	1	3	54	8	0.3	3.9	0.64	96.2	84.0814	50.6309
2015	7	1	4	4	8	0.3	3.9	0.65	95.8	84.0814	51.6748
2015	7	1	4	14	8	0.3	3.9	0.66	95.7	84.0814	52.1968
2015	7	1	4	24	8	0.3	3.9	0.65	93.2	84.0814	51.6748
2015	7	1	4	34	8	0.3	3.9	0.69	96.3	84.147	54.3287
2015	7	1	4	44	8	0.3	3.9	0.7	96.7	84.147	55.6346
2015	7	1	4	54	8	0.3	3.9	0.69	99.9	84.147	54.0675
2015	7	1	5	4	8	0.3	3.9	0.68	97.2	84.147	53.8063
2015	7	1	5	14	8	0.3	3.9	0.68	95.6	84.147	53.5451
2015	7	1	5	24	8	0.3	3.9	0.67	96.2	84.147	53.0227
2015	7	1	5	34	8	0.3	3.9	0.64	94.1	84.147	50.672
2015	7	1	5	44	8	0.3	3.9	0.68	97.7	84.147	53.8063
2015	7	1	5	54	8	0.3	3.9	0.68	94.7	84.2126	54.1113
2015	7	1	6	4	8	0.3	3.9	0.68	97.2	84.0814	54.0238
2015	7	1	6	14	8	0.3	3.9	0.72	94.2	84.147	57.4631
2015	7	1	6	24	8	0.3	3.9	0.66	96	84.2126	52.0201
2015	7	1	6	34	8	0.3	3.9	0.67	94.5	84.3438	53.6753
2015	7	1	6	44	8	0.3	3.9	0.66	95.7	84.3438	52.6279
2015	7	1	6	54	8	0.3	3.9	0.7	96	84.3438	55.2463
2015	7	1	7	4	8	0.3	3.9	0.7	97.6	84.3438	55.2463
2015	7	1	7	14	8	0.3	3.9	0.7	99.8	84.4095	54.7668
2015	7	1	7	24	8	0.3	3.9	0.63	91.8	84.3438	50.5333
2015	7	1	7	34	8	0.3	3.9	0.65	94.7	84.4095	51.3603
2015	7	1	7	44	8	0.3	3.9	0.65	94.7	84.3438	51.3188

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	1	7	54	8	0.3	3.9	0.67	94.2	84.4095	53.1946
2015	7	1	8	4	8	0.3	3.9	0.7	96.8	84.4095	55.2909
2015	7	1	8	14	8	0.3	3.9	0.66	95.5	84.4095	52.1464
2015	7	1	8	24	8	0.3	3.9	0.68	98.3	84.4095	53.7187
2015	7	1	8	34	8	0.3	3.9	0.66	96.6	84.4095	52.4085
2015	7	1	8	44	8	0.3	3.9	0.69	97.1	84.4095	54.7668
2015	7	1	8	54	8	0.3	3.9	0.69	97.1	84.4095	54.7668
2015	7	1	9	4	8	0.3	3.9	0.73	96.5	84.3438	57.8646
2015	7	1	9	14	8	0.3	3.9	0.68	98.8	84.3438	53.9372
2015	7	1	9	24	8	0.3	3.9	0.7	96.7	84.4095	55.815
2015	7	1	9	34	8	0.3	3.9	0.69	95.7	84.3438	54.7227
2015	7	1	9	44	8	0.3	3.9	0.69	98.7	84.4095	54.7669
2015	7	1	9	54	8	0.3	3.9	0.67	99	84.4095	52.9326
2015	7	1	10	4	8	0.3	3.9	0.68	95.6	84.4095	53.7187
2015	7	1	10	14	8	0.3	3.9	0.69	97.1	84.4751	55.0733
2015	7	1	10	24	8	0.3	3.9	0.69	94.4	84.5407	55.1177
2015	7	1	10	34	8	0.3	3.9	0.69	93.5	84.5407	55.3802
2015	7	1	10	44	8	0.3	3.9	0.68	90.8	84.6063	54.1115
2015	7	1	10	54	8	0.3	3.9	0.7	96.2	84.6063	55.4249
2015	7	1	11	4	8	0.3	3.9	0.67	95.9	84.6063	53.5861
2015	7	1	11	14	8	0.3	3.9	0.7	97.6	84.6063	55.1622
2015	7	1	11	24	8	0.3	3.9	0.68	94.4	84.6063	54.6368
2015	7	1	11	34	8	0.3	3.9	0.68	94.4	84.6063	54.1114
2015	7	1	11	44	8	0.3	3.9	0.69	98.7	84.6063	54.8995
2015	7	1	11	54	8	0.3	3.9	0.68	95.5	84.6719	54.155
2015	7	1	12	4	8	0.3	3.9	0.68	97	84.6719	53.8921
2015	7	1	12	14	8	0.3	3.9	0.7	97.6	84.6719	55.2066
2015	7	1	12	24	8	0.3	3.9	0.69	97.9	84.6719	54.9437
2015	7	1	12	34	8	0.3	3.9	0.71	97.2	84.6719	56.2581
2015	7	1	12	44	8	0.3	3.9	0.67	97.3	84.6719	53.3663
2015	7	1	12	54	8	0.3	3.9	0.72	96.5	84.6719	57.3096
2015	7	1	13	4	8	0.3	3.9	0.7	98.6	84.6719	55.4694
2015	7	1	13	14	8	0.3	3.9	0.67	99.3	84.6719	52.8406
2015	7	1	13	24	8	0.3	3.9	0.68	98.3	84.6719	53.8921
2015	7	1	13	34	8	0.3	3.9	0.68	97.5	84.6719	53.6292
2015	7	1	13	44	8	0.3	3.9	0.7	95.7	84.6719	55.4694
2015	7	1	13	54	8	0.3	3.9	0.71	98.5	84.6719	55.9952
2015	7	1	14	4	8	0.3	3.9	0.7	100.6	84.7375	54.9878
2015	7	1	14	14	8	0.3	3.9	0.69	99.2	84.7375	54.9878
2015	7	1	14	24	8	0.3	3.9	0.71	101.3	84.6719	55.4693
2015	7	1	14	34	8	0.3	3.9	0.67	100.7	84.6719	52.8404
2015	7	1	14	44	8	0.3	3.9	0.69	101.5	84.6719	54.1549
2015	7	1	14	54	8	0.3	3.9	0.68	99.5	84.6719	53.6291
2015	7	1	15	4	8	0.3	3.9	0.68	97.2	84.6719	54.1549
2015	7	1	15	14	8	0.3	3.9	0.68	99.8	84.6719	53.3662
2015	7	1	15	24	8	0.3	3.9	0.71	101.3	84.6719	55.4694
2015	7	1	15	34	8	0.3	3.9	0.69	101.3	84.6719	54.1549

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	1	15	44	8	0.3	3.9	0.68	101.6	84.6719	53.6292
2015	7	1	15	54	8	0.3	3.9	0.69	101	84.6063	54.1114
2015	7	1	16	4	8	0.3	3.9	0.72	98.9	84.6063	57.0008
2015	7	1	16	14	8	0.3	3.9	0.72	99.2	84.6719	56.7838
2015	7	1	16	24	8	0.3	3.9	0.7	100	84.6063	55.1621
2015	7	1	16	34	8	0.3	3.9	0.69	100.2	84.6719	54.1549
2015	7	1	16	44	8	0.3	3.9	0.71	99	84.6719	56.258
2015	7	1	16	54	8	0.3	3.9	0.7	98.1	84.6719	55.2065
2015	7	1	17	4	8	0.3	3.9	0.69	101.2	84.6063	54.3741
2015	7	1	17	14	8	0.3	3.9	0.69	99.9	84.6063	54.1114
2015	7	1	17	24	8	0.3	3.9	0.69	97.1	84.6719	55.2065
2015	7	1	17	34	8	0.3	3.9	0.69	100.1	84.6063	54.6367
2015	7	1	17	44	8	0.3	3.9	0.71	97.4	84.6719	56.521
2015	7	1	17	54	8	0.3	3.9	0.71	98.8	84.6063	55.9501
2015	7	1	18	4	8	0.3	3.9	0.7	98.6	84.6719	55.4694
2015	7	1	18	14	8	0.3	3.9	0.68	95.5	84.6719	54.155
2015	7	1	18	24	8	0.3	3.9	0.7	100.3	84.6719	55.2065
2015	7	1	18	34	8	0.3	3.9	0.7	100.2	84.6719	55.4694
2015	7	1	18	44	8	0.3	3.9	0.73	98.3	84.6719	57.5725
2015	7	1	18	54	8	0.3	3.9	0.73	99.3	84.6719	57.5725
2015	7	1	19	4	8	0.3	3.9	0.69	100.1	84.6719	54.4179
2015	7	1	19	14	8	0.3	3.9	0.7	99.7	84.6719	55.4694
2015	7	1	19	24	8	0.3	3.9	0.7	98.1	84.6719	55.2065
2015	7	1	19	34	8	0.3	3.9	0.7	97.6	84.7375	55.514
2015	7	1	19	44	8	0.3	3.9	0.69	94.3	84.7375	55.514
2015	7	1	19	54	8	0.3	3.9	0.68	99.1	84.7375	54.1985
2015	7	1	20	4	8	0.3	3.9	0.66	96.6	84.7375	52.6199
2015	7	1	20	14	8	0.3	3.9	0.68	99.4	84.7375	54.1985
2015	7	1	20	24	8	0.3	3.9	0.63	96.3	84.7375	49.9889
2015	7	1	20	34	8	0.3	3.9	0.67	96.8	84.7375	53.1461
2015	7	1	20	44	8	0.3	3.9	0.68	95	84.7375	53.9354
2015	7	1	20	54	8	0.3	3.9	0.7	96.2	84.8032	56.0853
2015	7	1	21	4	8	0.3	3.9	0.68	95.8	84.8032	54.2421
2015	7	1	21	14	8	0.3	3.9	0.69	96	84.8032	55.032
2015	7	1	21	24	8	0.3	3.9	0.67	95.9	84.8032	53.7154
2015	7	1	21	34	8	0.3	3.9	0.7	97.5	84.8032	56.0852
2015	7	1	21	44	8	0.3	3.9	0.67	97.7	84.8032	52.9255
2015	7	1	21	54	8	0.3	3.9	0.69	99	84.8032	54.7687
2015	7	1	22	4	8	0.3	3.9	0.7	97.3	84.8688	55.6032
2015	7	1	22	14	8	0.3	3.9	0.68	97.2	84.8688	54.5491
2015	7	1	22	24	8	0.3	3.9	0.68	97.5	84.8688	54.0221
2015	7	1	22	34	8	0.3	3.9	0.71	95.6	84.8688	56.6573
2015	7	1	22	44	8	0.3	3.9	0.68	96.1	84.8688	54.2856
2015	7	1	22	54	8	0.3	3.9	0.7	96.2	84.8688	55.8667
2015	7	1	23	4	8	0.3	3.9	0.69	95.2	84.8688	55.0761
2015	7	1	23	14	8	0.3	3.9	0.66	97.7	84.8688	52.4409
2015	7	1	23	24	8	0.3	3.9	0.71	99.9	84.8688	55.8667

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	1	23	34	8	0.3	3.9	0.68	97	84.8688	54.022
2015	7	1	23	44	8	0.3	3.9	0.69	95.7	84.9344	55.1203
2015	7	1	23	54	8	0.3	3.9	0.69	97.1	84.9344	55.1203
2015	7	2	0	4	8	0.3	3.9	0.71	96.1	84.9344	56.7027
2015	7	2	0	14	8	0.3	3.9	0.69	95.7	84.9344	55.1203
2015	7	2	0	24	8	0.3	3.9	0.67	96.7	84.9344	53.8017
2015	7	2	0	34	8	0.3	3.9	0.69	95.7	84.9344	55.3841
2015	7	2	0	44	8	0.3	3.9	0.69	98.4	84.9344	55.1203
2015	7	2	0	54	8	0.3	3.9	0.66	95.5	85	52.5251
2015	7	2	1	4	8	0.3	3.9	0.65	95.5	84.9344	51.9555
2015	7	2	1	14	8	0.3	3.9	0.69	97.1	85	55.1645
2015	7	2	1	24	8	0.3	3.9	0.68	95.6	85	54.1087
2015	7	2	1	34	8	0.3	3.9	0.68	98	84.9344	54.3291
2015	7	2	1	44	8	0.3	3.9	0.68	94.4	85	54.9006
2015	7	2	1	54	8	0.3	3.9	0.66	95.7	85	53.053
2015	7	2	2	4	8	0.3	3.9	0.66	94.8	85	53.053
2015	7	2	2	14	8	0.3	3.9	0.7	94	85	55.9564
2015	7	2	2	24	8	0.3	3.9	0.7	97.6	85	55.4285
2015	7	2	2	34	8	0.3	3.9	0.69	96.6	85	55.1645
2015	7	2	2	44	8	0.3	3.9	0.68	95.5	85.0656	54.6804
2015	7	2	2	54	8	0.3	3.9	0.69	98.2	85.0656	54.9446
2015	7	2	3	4	8	0.3	3.9	0.67	97.3	85.0656	53.888
2015	7	2	3	14	8	0.3	3.9	0.65	96.9	85.0656	52.0389
2015	7	2	3	24	8	0.3	3.9	0.67	93.1	85.0656	54.1521
2015	7	2	3	34	8	0.3	3.9	0.67	94.8	85.0656	53.3597
2015	7	2	3	44	8	0.3	3.9	0.72	97.9	85.1312	57.3679
2015	7	2	3	54	8	0.3	3.9	0.67	95.6	85.1312	53.6668
2015	7	2	4	4	8	0.3	3.9	0.69	100.1	85.1312	54.9886
2015	7	2	4	14	8	0.3	3.9	0.72	94.7	85.1312	57.6323
2015	7	2	4	24	8	0.3	3.9	0.69	100.4	85.1969	55.0326
2015	7	2	4	34	8	0.3	3.9	0.68	97.2	85.1969	54.768
2015	7	2	4	44	8	0.3	3.9	0.72	98.4	85.1969	57.4138
2015	7	2	4	54	8	0.3	3.9	0.72	95.5	85.1969	57.4138
2015	7	2	5	4	8	0.3	3.9	0.7	94.8	85.1969	56.3555
2015	7	2	5	14	8	0.3	3.9	0.68	95.6	85.2625	54.2822
2015	7	2	5	24	8	0.3	3.9	0.69	96.3	85.2625	55.6062
2015	7	2	5	34	8	0.3	3.9	0.68	97.2	85.3281	54.5906
2015	7	2	5	44	8	0.3	3.9	0.69	97.1	85.3937	55.6951
2015	7	2	5	54	8	0.3	3.9	0.69	98	85.3937	54.8994
2015	7	2	6	4	8	0.3	3.9	0.69	99.6	85.4593	54.6778
2015	7	2	6	14	8	0.3	3.9	0.7	97.8	85.4593	56.2703
2015	7	2	6	24	8	0.3	3.9	0.69	97.1	85.4593	55.4741
2015	7	2	6	34	8	0.3	3.9	0.68	94.4	85.4593	54.6778
2015	7	2	6	44	8	0.3	3.9	0.7	98.7	85.4593	55.7395
2015	7	2	6	54	8	0.3	3.9	0.69	96.6	85.5249	55.5183
2015	7	2	7	4	8	0.3	3.9	0.7	93	85.5249	56.3152
2015	7	2	7	14	8	0.3	3.9	0.71	96.9	85.5249	57.1121

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	2	7	24	8	0.3	3.9	0.72	96.1	85.5249	57.6434
2015	7	2	7	34	8	0.3	3.9	0.71	96.6	85.5249	57.1121
2015	7	2	7	44	8	0.3	3.9	0.69	96	85.5249	55.5183
2015	7	2	7	54	8	0.3	3.9	0.72	96.1	85.5249	57.6434
2015	7	2	8	4	8	0.3	3.9	0.68	98.3	85.5249	54.7214
2015	7	2	8	14	8	0.3	3.9	0.71	98	85.5906	56.6259
2015	7	2	8	24	8	0.3	3.9	0.7	96	85.5906	56.0942
2015	7	2	8	34	8	0.3	3.9	0.7	96.2	85.5906	56.0942
2015	7	2	8	44	8	0.3	3.9	0.67	98.7	85.5906	53.7015
2015	7	2	8	54	8	0.3	3.9	0.69	96.9	85.5906	55.2966
2015	7	2	9	4	8	0.3	3.9	0.71	97.7	85.5906	56.8917
2015	7	2	9	14	8	0.3	3.9	0.7	97.5	85.5906	56.6259
2015	7	2	9	24	8	0.3	3.9	0.69	96.9	85.5906	55.2966
2015	7	2	9	34	8	0.3	3.9	0.69	100.4	85.5906	55.2966
2015	7	2	9	44	8	0.3	3.9	0.7	97	85.6562	56.1388
2015	7	2	9	54	8	0.3	3.9	0.7	97.5	85.6562	56.4048
2015	7	2	10	4	8	0.3	3.9	0.7	98.1	85.6562	55.8727
2015	7	2	10	14	8	0.3	3.9	0.66	97.1	85.6562	53.2121
2015	7	2	10	24	8	0.3	3.9	0.69	100.4	85.5906	55.2966
2015	7	2	10	34	8	0.3	3.9	0.71	98.7	85.6562	57.203
2015	7	2	10	44	8	0.3	3.9	0.71	98.2	85.6562	57.203
2015	7	2	10	54	8	0.3	3.9	0.75	96.6	85.6562	60.1297
2015	7	2	11	4	8	0.3	3.9	0.73	98.3	85.6562	58.2672
2015	7	2	11	14	8	0.3	3.9	0.72	99.2	85.6562	57.7351
2015	7	2	11	24	8	0.3	3.9	0.7	98.1	85.6562	55.8727
2015	7	2	11	34	8	0.3	3.9	0.69	98.7	85.6562	55.6066
2015	7	2	11	44	8	0.3	3.9	0.68	95.8	85.6562	54.5424
2015	7	2	11	54	8	0.3	3.9	0.68	98.9	85.6562	54.5423
2015	7	2	12	4	8	0.3	3.9	0.72	98.4	85.6562	57.469
2015	7	2	12	14	8	0.3	3.9	0.71	97.2	85.6562	56.9369
2015	7	2	12	24	8	0.3	3.9	0.69	97.7	85.6562	55.3405
2015	7	2	12	34	8	0.3	3.9	0.7	97.5	85.6562	56.4048
2015	7	2	12	44	8	0.3	3.9	0.71	99.6	85.7218	56.4496
2015	7	2	12	54	8	0.3	3.9	0.69	95.8	85.7218	55.3845
2015	7	2	13	4	8	0.3	3.9	0.69	98.4	85.7218	55.6507
2015	7	2	13	14	8	0.3	3.9	0.71	97.4	85.7218	57.2483
2015	7	2	13	24	8	0.3	3.9	0.69	98.5	85.7218	55.1182
2015	7	2	13	34	8	0.3	3.9	0.68	95.2	85.7218	55.1182
2015	7	2	13	44	8	0.3	3.9	0.71	96.4	85.6562	56.9368
2015	7	2	13	54	8	0.3	3.9	0.72	98.9	85.6562	58.0011
2015	7	2	14	4	8	0.3	3.9	0.71	97.2	85.7218	56.9821
2015	7	2	14	14	8	0.3	3.9	0.65	97	85.7218	52.1891
2015	7	2	14	24	8	0.3	3.9	0.71	99.2	85.6562	57.2028
2015	7	2	14	34	8	0.3	3.9	0.72	99.7	85.5906	57.6891
2015	7	2	14	44	8	0.3	3.9	0.69	97.1	85.5906	55.8282
2015	7	2	14	54	8	0.3	3.9	0.74	100.2	85.6562	59.3313
2015	7	2	15	4	8	0.3	3.9	0.7	100.3	85.7218	55.9169

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	2	15	14	8	0.3	3.9	0.68	101.1	85.6562	54.0101
2015	7	2	15	24	8	0.3	3.9	0.68	100.3	85.7218	54.0531
2015	7	2	15	34	8	0.3	3.9	0.72	98.9	85.7218	58.0471
2015	7	2	15	44	8	0.3	3.9	0.71	98	85.7218	56.7157
2015	7	2	15	54	8	0.3	3.9	0.71	96.6	85.6562	57.2028
2015	7	2	16	4	8	0.3	3.9	0.71	99.9	85.6562	56.6707
2015	7	2	16	14	8	0.3	3.9	0.7	97.5	85.7218	56.7157
2015	7	2	16	24	8	0.3	3.9	0.72	98.4	85.7218	57.5145
2015	7	2	16	34	8	0.3	3.9	0.74	99.2	85.7218	59.3784
2015	7	2	16	44	8	0.3	3.9	0.71	95.6	85.7218	57.5145
2015	7	2	16	54	8	0.3	3.9	0.73	101	85.6562	57.7349
2015	7	2	17	4	8	0.3	3.9	0.73	99.6	85.6562	58.267
2015	7	2	17	14	8	0.3	3.9	0.71	100.1	85.7218	56.7157
2015	7	2	17	24	8	0.3	3.9	0.73	98.3	85.7218	58.3134
2015	7	2	17	34	8	0.3	3.9	0.71	100.4	85.7218	56.7157
2015	7	2	17	44	8	0.3	3.9	0.73	97.7	85.7218	59.1122
2015	7	2	17	54	8	0.3	3.9	0.68	100.2	85.7218	54.5856
2015	7	2	18	4	8	0.3	3.9	0.69	101.6	85.7218	54.5856
2015	7	2	18	14	8	0.3	3.9	0.71	99.2	85.7218	57.2483
2015	7	2	18	24	8	0.3	3.9	0.73	98.8	85.7218	58.3134
2015	7	2	18	34	8	0.3	3.9	0.73	101.7	85.7218	58.0471
2015	7	2	18	44	8	0.3	3.9	0.68	99.8	85.7218	54.053
2015	7	2	18	54	8	0.3	3.9	0.72	96.1	85.7218	57.7808
2015	7	2	19	4	8	0.3	3.9	0.72	97.3	85.7218	58.0471
2015	7	2	19	14	8	0.3	3.9	0.7	100	85.7218	55.9169
2015	7	2	19	24	8	0.3	3.9	0.72	99.7	85.7218	57.7808
2015	7	2	19	34	8	0.3	3.9	0.69	96.8	85.7218	55.9169
2015	7	2	19	44	8	0.3	3.9	0.72	97.6	85.7218	58.0471
2015	7	2	19	54	8	0.3	3.9	0.71	95.6	85.7218	57.2483
2015	7	2	20	4	8	0.3	3.9	0.72	98.6	85.7874	58.0932
2015	7	2	20	14	8	0.3	3.9	0.7	98.9	85.7874	55.9613
2015	7	2	20	24	8	0.3	3.9	0.69	95.7	85.7874	55.6948
2015	7	2	20	34	8	0.3	3.9	0.7	97.2	85.7874	56.7608
2015	7	2	20	44	8	0.3	3.9	0.67	94.8	85.7874	54.0959
2015	7	2	20	54	8	0.3	3.9	0.67	95.3	85.7874	54.3624
2015	7	2	21	4	8	0.3	3.9	0.72	96.8	85.7874	58.0932
2015	7	2	21	14	8	0.3	3.9	0.68	95.3	85.7874	54.8954
2015	7	2	21	24	8	0.3	3.9	0.7	97	85.7874	56.7608
2015	7	2	21	34	8	0.3	3.9	0.72	96.3	85.853	58.1393
2015	7	2	21	44	8	0.3	3.9	0.7	98.6	85.853	56.5391
2015	7	2	21	54	8	0.3	3.9	0.71	95.6	85.853	57.3392
2015	7	2	22	4	8	0.3	3.9	0.68	94.9	85.853	55.4724
2015	7	2	22	14	8	0.3	3.9	0.7	97.8	85.853	56.2724
2015	7	2	22	24	8	0.3	3.9	0.68	95.8	85.853	54.6723
2015	7	2	22	34	8	0.3	3.9	0.71	95.8	85.853	57.6059
2015	7	2	22	44	8	0.3	3.9	0.65	95.8	85.853	52.5387
2015	7	2	22	54	8	0.3	3.9	0.72	95.5	85.853	57.8726

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	2	23	4	8	0.3	3.9	0.7	96.7	85.9186	56.8509
2015	7	2	23	14	8	0.3	3.9	0.7	99.4	85.9186	56.584
2015	7	2	23	24	8	0.3	3.9	0.7	96.7	85.9186	56.8509
2015	7	2	23	34	8	0.3	3.9	0.71	98.8	85.9186	56.8509
2015	7	2	23	44	8	0.3	3.9	0.7	96.2	85.9186	56.584
2015	7	2	23	54	8	0.3	3.9	0.69	97.9	85.9186	55.7833
2015	7	3	0	4	8	0.3	3.9	0.74	96.9	85.9186	59.5199
2015	7	3	0	14	8	0.3	3.9	0.68	99.1	85.9186	54.7156
2015	7	3	0	24	8	0.3	3.9	0.7	97	85.9843	56.8959
2015	7	3	0	34	8	0.3	3.9	0.69	97.9	85.9843	55.8275
2015	7	3	0	44	8	0.3	3.9	0.68	93.9	85.9843	55.0261
2015	7	3	0	54	8	0.3	3.9	0.7	97.2	85.9843	56.896
2015	7	3	1	4	8	0.3	3.9	0.7	97.5	85.9843	56.896
2015	7	3	1	14	8	0.3	3.9	0.71	96.4	85.9843	57.1631
2015	7	3	1	24	8	0.3	3.9	0.68	96.9	85.9843	55.2933
2015	7	3	1	34	8	0.3	3.9	0.7	97.5	85.9843	56.896
2015	7	3	1	44	8	0.3	3.9	0.72	98.2	86.0499	57.743
2015	7	3	1	54	8	0.3	3.9	0.69	93.3	86.0499	56.4064
2015	7	3	2	4	8	0.3	3.9	0.69	97.4	86.2467	56.0044
2015	7	3	2	14	8	0.3	3.9	0.71	95.3	86.1811	57.5667
2015	7	3	2	24	8	0.3	3.9	0.7	97.6	86.1811	56.2279
2015	7	3	2	34	8	0.3	3.9	0.69	93.8	86.2467	56.5403
2015	7	3	2	44	8	0.3	3.9	0.72	95.8	86.2467	58.4161
2015	7	3	2	54	8	0.3	3.9	0.7	94.6	86.3123	56.8532
2015	7	3	3	4	8	0.3	3.9	0.72	94.7	86.3123	58.4622
2015	7	3	3	14	8	0.3	3.9	0.72	97.6	86.3123	58.4622
2015	7	3	3	24	8	0.3	3.9	0.7	97.5	86.3123	56.8532
2015	7	3	3	34	8	0.3	3.9	0.69	98.2	86.3123	55.7805
2015	7	3	3	44	8	0.3	3.9	0.69	97.1	86.3123	56.3169
2015	7	3	3	54	8	0.3	3.9	0.73	98.1	86.3123	58.7304
2015	7	3	4	4	8	0.3	3.9	0.71	94.8	86.378	57.7032
2015	7	3	4	14	8	0.3	3.9	0.7	98.1	86.378	56.8981
2015	7	3	4	24	8	0.3	3.9	0.72	97.3	86.378	58.5084
2015	7	3	4	34	8	0.3	3.9	0.7	97.8	86.378	56.8981
2015	7	3	4	44	8	0.3	3.9	0.7	95.6	86.378	57.1665
2015	7	3	4	54	8	0.3	3.9	0.71	95	86.378	57.9717
2015	7	3	5	4	8	0.3	3.9	0.74	96.1	86.378	60.1188
2015	7	3	5	14	8	0.3	3.9	0.72	96	86.4436	58.5546
2015	7	3	5	24	8	0.3	3.9	0.7	95.7	86.4436	56.6744
2015	7	3	5	34	8	0.3	3.9	0.71	94.2	86.4436	58.286
2015	7	3	5	44	8	0.3	3.9	0.7	96.5	86.4436	56.943
2015	7	3	5	54	8	0.3	3.9	0.68	97.4	86.4436	55.6
2015	7	3	6	4	8	0.3	3.9	0.7	95.1	86.4436	56.943
2015	7	3	6	14	8	0.3	3.9	0.71	96.1	86.4436	57.7488
2015	7	3	6	24	8	0.3	3.9	0.72	95	86.4436	58.8232
2015	7	3	6	34	8	0.3	3.9	0.71	94.7	86.4436	58.2861
2015	7	3	6	44	8	0.3	3.9	0.7	98.6	86.4436	56.9431

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	3	6	54	8	0.3	3.9	0.71	97.7	86.4436	57.4803
2015	7	3	7	4	8	0.3	3.9	0.65	95.2	86.4436	53.1827
2015	7	3	7	14	8	0.3	3.9	0.69	95.4	86.5092	56.4503
2015	7	3	7	24	8	0.3	3.9	0.7	95.7	86.5092	56.9879
2015	7	3	7	34	8	0.3	3.9	0.69	97.1	86.5092	56.4503
2015	7	3	7	44	8	0.3	3.9	0.69	97.1	86.5092	56.1815
2015	7	3	7	54	8	0.3	3.9	0.71	96.9	86.5092	57.7944
2015	7	3	8	4	8	0.3	3.9	0.7	97.3	86.5092	56.9879
2015	7	3	8	14	8	0.3	3.9	0.69	96.8	86.5092	56.4503
2015	7	3	8	24	8	0.3	3.9	0.71	95.3	86.5092	57.7944
2015	7	3	8	34	8	0.3	3.9	0.72	99.7	86.5092	58.0632
2015	7	3	8	44	8	0.3	3.9	0.74	97.9	86.5092	59.676
2015	7	3	8	54	8	0.3	3.9	0.72	97.4	86.5092	58.332
2015	7	3	9	4	8	0.3	3.9	0.69	96	86.5092	56.1815
2015	7	3	9	14	8	0.3	3.9	0.7	95.4	86.5092	56.9879
2015	7	3	9	24	8	0.3	3.9	0.7	99.9	86.5092	56.7191
2015	7	3	9	34	8	0.3	3.9	0.72	96.6	86.5092	58.3319
2015	7	3	9	44	8	0.3	3.9	0.75	96.6	86.5092	60.7512
2015	7	3	9	54	8	0.3	3.9	0.71	96.4	86.5092	57.5255
2015	7	3	10	4	8	0.3	3.9	0.72	99.1	86.5748	58.6468
2015	7	3	10	14	8	0.3	3.9	0.72	98.2	86.5092	58.0631
2015	7	3	10	24	8	0.3	3.9	0.73	97.4	86.5748	59.7229
2015	7	3	10	34	8	0.3	3.9	0.71	97.7	86.5748	57.5708
2015	7	3	10	44	8	0.3	3.9	0.7	98.8	86.5748	57.0327
2015	7	3	10	54	8	0.3	3.9	0.71	101.2	86.5092	56.9878
2015	7	3	11	4	8	0.3	3.9	0.68	98.8	86.5092	55.375
2015	7	3	11	14	8	0.3	3.9	0.72	102.4	86.5092	57.5254
2015	7	3	11	24	8	0.3	3.9	0.72	97.6	86.5092	58.063
2015	7	3	11	34	8	0.3	3.9	0.73	101	86.5748	58.3777
2015	7	3	11	44	8	0.3	3.9	0.69	103.2	86.5092	54.8373
2015	7	3	11	54	8	0.3	3.9	0.75	101.3	86.5092	60.4823
2015	7	3	12	4	8	0.3	3.9	0.73	99.3	86.5092	59.1382
2015	7	3	12	14	8	0.3	3.9	0.71	100.7	86.5092	56.9878
2015	7	3	12	24	8	0.3	3.9	0.69	98.5	86.5748	55.6875
2015	7	3	12	34	8	0.3	3.9	0.73	103.7	86.5092	58.3318
2015	7	3	12	44	8	0.3	3.9	0.69	102.7	86.5748	54.8804
2015	7	3	12	54	8	0.3	3.9	0.74	98.2	86.5092	59.9446
2015	7	3	13	4	8	0.3	3.9	0.71	100.2	86.5092	56.9877
2015	7	3	13	14	8	0.3	3.9	0.74	102	86.4436	59.6288
2015	7	3	13	24	8	0.3	3.9	0.71	100.3	86.4436	57.48
2015	7	3	13	34	8	0.3	3.9	0.69	100.9	86.5092	55.6436
2015	7	3	13	44	8	0.3	3.9	0.77	101.5	86.5092	62.0951
2015	7	3	13	54	8	0.3	3.9	0.77	103.6	86.5092	61.2887
2015	7	3	14	4	8	0.3	3.9	0.71	98.5	86.5092	57.2565
2015	7	3	14	14	8	0.3	3.9	0.76	97.2	86.5092	62.0951
2015	7	3	14	24	8	0.3	3.9	0.7	101.6	86.5092	56.4501
2015	7	3	14	34	8	0.3	3.9	0.7	101.3	86.4436	56.4056

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	3	14	44	8	0.3	3.9	0.72	98.4	86.5092	58.3317
2015	7	3	14	54	8	0.3	3.9	0.72	104.9	86.4436	56.6742
2015	7	3	15	4	8	0.3	3.9	0.68	96.4	86.5092	55.106
2015	7	3	15	14	8	0.3	3.9	0.67	100.9	86.4436	54.2569
2015	7	3	15	24	8	0.3	3.9	0.72	99.2	86.378	58.2399
2015	7	3	15	34	8	0.3	3.9	0.66	101	86.378	52.6038
2015	7	3	15	44	8	0.3	3.9	0.7	98.4	86.5092	56.7189
2015	7	3	15	54	8	0.3	3.9	0.7	101.4	86.4436	55.8685
2015	7	3	16	4	8	0.3	3.9	0.62	102.5	86.4436	49.6907
2015	7	3	16	14	8	0.3	3.9	0.72	99.2	86.378	58.2399
2015	7	3	16	24	8	0.3	3.9	0.73	96.7	86.4436	59.3602
2015	7	3	16	34	8	0.3	3.9	0.7	99.7	86.5092	56.7189
2015	7	3	16	44	8	0.3	3.9	0.73	101.7	86.5092	58.6006
2015	7	3	16	54	8	0.3	3.9	0.72	99.8	86.5092	57.7941
2015	7	3	17	4	8	0.3	3.9	0.72	96.8	86.5092	58.6006
2015	7	3	17	14	8	0.3	3.9	0.72	97.3	86.5748	58.6467
2015	7	3	17	24	8	0.3	3.9	0.72	99.4	86.4436	58.2858
2015	7	3	17	34	8	0.3	3.9	0.72	98.2	86.5092	58.0629
2015	7	3	17	44	8	0.3	3.9	0.72	96.8	86.5748	58.3776
2015	7	3	17	54	8	0.3	3.9	0.7	96.5	86.5748	56.7635
2015	7	3	18	4	8	0.3	3.9	0.74	99.9	86.5092	59.9446
2015	7	3	18	14	8	0.3	3.9	0.74	99.2	86.5092	59.9446
2015	7	3	18	24	8	0.3	3.9	0.72	98.9	86.5092	58.6005
2015	7	3	18	34	8	0.3	3.9	0.66	94.9	86.5092	53.4931
2015	7	3	18	44	8	0.3	3.9	0.71	99.9	86.5092	57.2565
2015	7	3	18	54	8	0.3	3.9	0.72	98.9	86.5748	58.6466
2015	7	3	19	4	8	0.3	3.9	0.7	95.7	86.5748	57.0325
2015	7	3	19	14	8	0.3	3.9	0.73	98.5	86.5748	59.1846
2015	7	3	19	24	8	0.3	3.9	0.71	96.7	86.5748	57.5705
2015	7	3	19	34	8	0.3	3.9	0.71	96.9	86.5748	57.8395
2015	7	3	19	44	8	0.3	3.9	0.7	94.3	86.5748	57.5705
2015	7	3	19	54	8	0.3	3.9	0.73	95.9	86.5748	59.7227
2015	7	3	20	4	8	0.3	3.9	0.72	97.9	86.5748	58.3775
2015	7	3	20	14	8	0.3	3.9	0.72	95.5	86.5748	58.3775
2015	7	3	20	24	8	0.3	3.9	0.73	97.3	86.5748	59.1846
2015	7	3	20	34	8	0.3	3.9	0.71	97.2	86.5748	57.5704
2015	7	3	20	44	8	0.3	3.9	0.72	95.8	86.5748	58.6465
2015	7	3	20	54	8	0.3	3.9	0.72	95.5	86.5748	58.6465
2015	7	3	21	4	8	0.3	3.9	0.71	96.1	86.5748	57.8395
2015	7	3	21	14	8	0.3	3.9	0.68	97.4	86.5748	55.6873
2015	7	3	21	24	8	0.3	3.9	0.73	96.5	86.6404	59.2311
2015	7	3	21	34	8	0.3	3.9	0.69	95.2	86.6404	56.0003
2015	7	3	21	44	8	0.3	3.9	0.71	96.7	86.6404	57.6157
2015	7	3	21	54	8	0.3	3.9	0.71	97.8	86.6404	57.3465
2015	7	3	22	4	8	0.3	3.9	0.72	95.5	86.6404	58.6926
2015	7	3	22	14	8	0.3	3.9	0.73	98.7	86.6404	59.5003
2015	7	3	22	24	8	0.3	3.9	0.72	95	86.6404	58.6926

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	3	22	34	8	0.3	3.9	0.71	95.6	86.6404	57.6157
2015	7	3	22	44	8	0.3	3.9	0.68	95	86.6404	55.7311
2015	7	3	22	54	8	0.3	3.9	0.69	97.1	86.6404	56.2695
2015	7	3	23	4	8	0.3	3.9	0.72	96.6	86.6404	58.4234
2015	7	3	23	14	8	0.3	3.9	0.68	95.8	86.706	55.5054
2015	7	3	23	24	8	0.3	3.9	0.72	96.6	86.706	58.4693
2015	7	3	23	34	8	0.3	3.9	0.7	97.8	86.706	56.8526
2015	7	3	23	44	8	0.3	3.9	0.73	96.7	86.706	59.2776
2015	7	3	23	54	8	0.3	3.9	0.7	94.3	86.706	57.3916
2015	7	4	0	4	8	0.3	3.9	0.71	96.3	86.706	58.1999
2015	7	4	0	14	8	0.3	3.9	0.71	98.5	86.706	57.3916
2015	7	4	0	24	8	0.3	3.9	0.74	94.6	86.706	60.3554
2015	7	4	0	34	8	0.3	3.9	0.71	93.4	86.706	58.4693
2015	7	4	0	44	8	0.3	3.9	0.72	96	86.706	59.0082
2015	7	4	0	54	8	0.3	3.9	0.7	96.7	86.706	57.1221
2015	7	4	1	4	8	0.3	3.9	0.71	96.1	86.706	57.9305
2015	7	4	1	14	8	0.3	3.9	0.74	95.6	86.706	60.3555
2015	7	4	1	24	8	0.3	3.9	0.71	97.5	86.7717	57.7063
2015	7	4	1	34	8	0.3	3.9	0.74	96.1	86.7717	60.4029
2015	7	4	1	44	8	0.3	3.9	0.73	98.3	86.7717	59.0546
2015	7	4	1	54	8	0.3	3.9	0.69	97.4	86.7717	56.3581
2015	7	4	2	4	8	0.3	3.9	0.72	96.8	86.7717	58.5153
2015	7	4	2	14	8	0.3	3.9	0.7	96.2	86.7717	57.1671
2015	7	4	2	24	8	0.3	3.9	0.72	95.5	86.7717	58.785
2015	7	4	2	34	8	0.3	3.9	0.74	96.1	86.7717	60.4029
2015	7	4	2	44	8	0.3	3.9	0.73	96.7	86.7717	59.3243
2015	7	4	2	54	8	0.3	3.9	0.72	95.5	86.7717	59.0547
2015	7	4	3	4	8	0.3	3.9	0.72	96.8	86.7717	58.785
2015	7	4	3	14	8	0.3	3.9	0.71	96.9	86.7717	58.2457
2015	7	4	3	24	8	0.3	3.9	0.7	97.2	86.8373	57.4819
2015	7	4	3	34	8	0.3	3.9	0.72	96.8	86.9029	58.8773
2015	7	4	3	44	8	0.3	3.9	0.73	95.4	86.9029	59.9577
2015	7	4	3	54	8	0.3	3.9	0.7	96.7	86.9685	57.572
2015	7	4	4	4	8	0.3	3.9	0.74	98.2	86.9685	60.0047
2015	7	4	4	14	8	0.3	3.9	0.71	96.4	87.0341	57.8876
2015	7	4	4	24	8	0.3	3.9	0.74	96.9	87.0341	60.5927
2015	7	4	4	34	8	0.3	3.9	0.72	95.2	87.0341	59.5106
2015	7	4	4	44	8	0.3	3.9	0.71	93.2	87.0997	58.4744
2015	7	4	4	54	8	0.3	3.9	0.7	95.6	87.0997	57.6622
2015	7	4	5	4	8	0.3	3.9	0.73	98.7	87.0997	59.8279
2015	7	4	5	14	8	0.3	3.9	0.73	97.3	87.0997	59.5572
2015	7	4	5	24	8	0.3	3.9	0.73	94.6	87.0997	60.3694
2015	7	4	5	34	8	0.3	3.9	0.7	95.6	87.0997	57.6623
2015	7	4	5	44	8	0.3	3.9	0.73	96.4	87.0997	60.0987
2015	7	4	5	54	8	0.3	3.9	0.71	97.9	87.0997	58.2037
2015	7	4	6	4	8	0.3	3.9	0.73	96.2	87.1654	59.8748
2015	7	4	6	14	8	0.3	3.9	0.7	95.4	87.1654	57.4364

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	4	6	24	8	0.3	3.9	0.74	95.9	87.1654	60.4166
2015	7	4	6	34	8	0.3	3.9	0.72	97.4	87.1654	58.7911
2015	7	4	6	44	8	0.3	3.9	0.69	94.9	87.1654	56.8946
2015	7	4	6	54	8	0.3	3.9	0.71	94.5	87.1654	58.5202
2015	7	4	7	4	8	0.3	3.9	0.72	98.6	87.1654	59.062
2015	7	4	7	14	8	0.3	3.9	0.7	95.6	87.231	57.7525
2015	7	4	7	24	8	0.3	3.9	0.71	95.3	87.1654	58.7911
2015	7	4	7	34	8	0.3	3.9	0.71	99	87.231	58.0236
2015	7	4	7	44	8	0.3	3.9	0.73	98	87.231	59.9216
2015	7	4	7	54	8	0.3	3.9	0.72	97.3	87.231	59.1082
2015	7	4	8	4	8	0.3	3.9	0.72	97.5	87.231	59.3793
2015	7	4	8	14	8	0.3	3.9	0.72	95.7	87.231	59.3793
2015	7	4	8	24	8	0.3	3.9	0.7	95.9	87.231	57.4814
2015	7	4	8	34	8	0.3	3.9	0.73	98.3	87.231	59.3793
2015	7	4	8	44	8	0.3	3.9	0.72	95.7	87.231	59.3793
2015	7	4	8	54	8	0.3	3.9	0.71	96.9	87.231	58.5659
2015	7	4	9	4	8	0.3	3.9	0.72	98.1	87.231	58.8371
2015	7	4	9	14	8	0.3	3.9	0.71	96.9	87.231	58.5659
2015	7	4	9	24	8	0.3	3.9	0.7	95.7	87.231	57.4814
2015	7	4	9	34	8	0.3	3.9	0.74	96.1	87.231	60.735
2015	7	4	9	44	8	0.3	3.9	0.73	97.2	87.231	60.1927
2015	7	4	9	54	8	0.3	3.9	0.71	95.3	87.2966	58.3403
2015	7	4	10	4	8	0.3	3.9	0.72	96.8	87.2966	58.8829
2015	7	4	10	14	8	0.3	3.9	0.72	96.8	87.2966	59.1543
2015	7	4	10	24	8	0.3	3.9	0.74	100.8	87.231	59.9216
2015	7	4	10	34	8	0.3	3.9	0.74	99.2	87.231	60.1927
2015	7	4	10	44	8	0.3	3.9	0.73	96.7	87.2966	60.2396
2015	7	4	10	54	8	0.3	3.9	0.71	97.1	87.2966	58.6115
2015	7	4	11	4	8	0.3	3.9	0.7	95.9	87.231	57.4813
2015	7	4	11	14	8	0.3	3.9	0.72	102	87.2966	58.6115
2015	7	4	11	24	8	0.3	3.9	0.73	98.3	87.2966	59.4255
2015	7	4	11	34	8	0.3	3.9	0.72	100.7	87.2966	58.6115
2015	7	4	11	44	8	0.3	3.9	0.73	99.8	87.231	59.6504
2015	7	4	11	54	8	0.3	3.9	0.73	102.2	87.231	58.8369
2015	7	4	12	4	8	0.3	3.9	0.71	95.3	87.231	58.8369
2015	7	4	12	14	8	0.3	3.9	0.73	97.4	87.1654	60.1457
2015	7	4	12	24	8	0.3	3.9	0.72	98.6	87.231	59.1081
2015	7	4	12	34	8	0.3	3.9	0.76	96.2	87.1654	62.3131
2015	7	4	12	44	8	0.3	3.9	0.76	95.4	87.1654	62.584
2015	7	4	12	54	8	0.3	3.9	0.75	96	87.1654	61.7712
2015	7	4	13	4	8	0.3	3.9	0.77	94.9	87.231	63.4463
2015	7	4	13	14	8	0.3	3.9	0.77	97.1	87.1654	63.3967
2015	7	4	13	24	8	0.3	3.9	0.79	97.9	87.231	64.2596
2015	7	4	13	34	8	0.3	3.9	0.75	99.3	87.231	61.2772
2015	7	4	13	44	8	0.3	3.9	0.77	98.4	87.1654	62.584
2015	7	4	13	54	8	0.3	3.9	0.69	93.8	87.231	57.2101
2015	7	4	14	4	8	0.3	3.9	0.74	98.5	87.231	60.1927

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	4	14	14	8	0.3	3.9	0.73	98.1	87.1654	59.3329
2015	7	4	14	24	8	0.3	3.9	0.72	95.5	87.231	59.3792
2015	7	4	14	34	8	0.3	3.9	0.72	98.1	87.2966	58.8829
2015	7	4	14	44	8	0.3	3.9	0.73	96.4	87.2966	60.2396
2015	7	4	14	54	8	0.3	3.9	0.71	99	87.2966	58.0688
2015	7	4	15	4	8	0.3	3.9	0.73	98	87.231	59.6504
2015	7	4	15	14	8	0.3	3.9	0.72	98.1	87.231	58.837
2015	7	4	15	24	8	0.3	3.9	0.72	95.5	87.2966	58.8829
2015	7	4	15	34	8	0.3	3.9	0.71	97.7	87.2966	58.0688
2015	7	4	15	44	8	0.3	3.9	0.73	95.9	87.2966	60.2397
2015	7	4	15	54	8	0.3	3.9	0.74	97.4	87.2966	60.7823
2015	7	4	16	4	8	0.3	3.9	0.74	95.1	87.2966	61.0537
2015	7	4	16	14	8	0.3	3.9	0.7	97.8	87.2966	57.2548
2015	7	4	16	24	8	0.3	3.9	0.69	96.9	87.3622	56.4848
2015	7	4	16	34	8	0.3	3.9	0.67	97	87.3622	55.127
2015	7	4	16	44	8	0.3	3.9	0.7	96.7	87.3622	57.8426
2015	7	4	16	54	8	0.3	3.9	0.68	96.9	87.2966	55.8981
2015	7	4	17	4	8	0.3	3.9	0.73	96.4	87.3622	60.2867
2015	7	4	17	14	8	0.3	3.9	0.72	95.8	87.3622	58.9289
2015	7	4	17	24	8	0.3	3.9	0.72	95.5	87.3622	59.2005
2015	7	4	17	34	8	0.3	3.9	0.67	93.1	87.3622	55.6702
2015	7	4	17	44	8	0.3	3.9	0.7	96.7	87.3622	57.8426
2015	7	4	17	54	8	0.3	3.9	0.7	94.9	87.4278	57.616
2015	7	4	18	4	8	0.3	3.9	0.7	95.4	87.4278	57.8877
2015	7	4	18	14	8	0.3	3.9	0.7	97.3	87.4278	57.616
2015	7	4	18	24	8	0.3	3.9	0.68	93.6	87.4278	56.5289
2015	7	4	18	34	8	0.3	3.9	0.74	97.9	87.3622	60.2867
2015	7	4	18	44	8	0.3	3.9	0.73	95.9	87.4934	60.3807
2015	7	4	18	54	8	0.3	3.9	0.73	96.4	87.5591	60.4277
2015	7	4	19	4	8	0.3	3.9	0.74	95.6	87.4934	60.9246
2015	7	4	19	14	8	0.3	3.9	0.74	92.3	87.5591	61.5164
2015	7	4	19	24	8	0.3	3.9	0.72	95.2	87.5591	59.8832
2015	7	4	19	34	8	0.3	3.9	0.72	94.2	87.4934	59.2927
2015	7	4	19	44	8	0.3	3.9	0.75	96.3	87.4934	61.7406
2015	7	4	19	54	8	0.3	3.9	0.7	98.6	87.4934	57.6608
2015	7	4	20	4	8	0.3	3.9	0.73	98	87.5591	59.8832
2015	7	4	20	14	8	0.3	3.9	0.73	96.7	87.6247	60.4746
2015	7	4	20	24	8	0.3	3.9	0.73	95.4	87.6247	60.747
2015	7	4	20	34	8	0.3	3.9	0.74	97.9	87.6903	60.5216
2015	7	4	20	44	8	0.3	3.9	0.73	95.4	87.6903	60.7942
2015	7	4	20	54	8	0.3	3.9	0.72	94.2	87.7559	59.4772
2015	7	4	21	4	8	0.3	3.9	0.72	95	87.7559	59.7501
2015	7	4	21	14	8	0.3	3.9	0.7	95.1	87.8215	58.4312
2015	7	4	21	24	8	0.3	3.9	0.72	96.8	87.8215	59.2503
2015	7	4	21	34	8	0.3	3.9	0.71	97.1	87.8215	58.9773
2015	7	4	21	44	8	0.3	3.9	0.72	97.3	87.8215	59.5234
2015	7	4	21	54	8	0.3	3.9	0.74	97.1	87.8871	61.4823

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	4	22	4	8	0.3	3.9	0.73	97.2	87.8871	60.6626
2015	7	4	22	14	8	0.3	3.9	0.75	96.3	87.8871	62.0288
2015	7	4	22	24	8	0.3	3.9	0.74	93.8	87.8871	61.4823
2015	7	4	22	34	8	0.3	3.9	0.74	93.6	87.8871	61.2091
2015	7	4	22	44	8	0.3	3.9	0.7	96	87.8871	57.6568
2015	7	4	22	54	8	0.3	3.9	0.74	98.2	87.9528	60.7096
2015	7	4	23	4	8	0.3	3.9	0.72	96.6	87.9528	59.3422
2015	7	4	23	14	8	0.3	3.9	0.71	95.3	87.9528	59.3422
2015	7	4	23	24	8	0.3	3.9	0.73	97.7	87.9528	60.7096
2015	7	4	23	34	8	0.3	3.9	0.72	97.6	87.9528	59.3423
2015	7	4	23	44	8	0.3	3.9	0.7	96	87.9528	57.7015
2015	7	4	23	54	8	0.3	3.9	0.73	95.4	88.0184	60.7566
2015	7	5	0	4	8	0.3	3.9	0.74	96.3	88.0184	61.5776
2015	7	5	0	14	8	0.3	3.9	0.72	95.2	88.0184	59.6619
2015	7	5	0	24	8	0.3	3.9	0.7	94.8	88.0184	58.2935
2015	7	5	0	34	8	0.3	3.9	0.72	95.8	88.0184	59.3882
2015	7	5	0	44	8	0.3	3.9	0.74	96.6	88.0184	61.5777
2015	7	5	0	54	8	0.3	3.9	0.72	97.3	88.0184	59.6619
2015	7	5	1	4	8	0.3	3.9	0.75	97	88.0184	62.1251
2015	7	5	1	14	8	0.3	3.9	0.7	97.6	88.0184	57.7462
2015	7	5	1	24	8	0.3	3.9	0.72	95	88.0184	59.9357
2015	7	5	1	34	8	0.3	3.9	0.75	94	88.0184	62.3988
2015	7	5	1	44	8	0.3	3.9	0.73	95.2	88.084	60.5298
2015	7	5	1	54	8	0.3	3.9	0.76	95.7	88.084	62.9949
2015	7	5	2	4	8	0.3	3.9	0.71	96.9	88.084	59.1604
2015	7	5	2	14	8	0.3	3.9	0.73	98.5	88.084	60.5299
2015	7	5	2	24	8	0.3	3.9	0.75	95.2	88.084	62.721
2015	7	5	2	34	8	0.3	3.9	0.72	97.6	88.084	59.1604
2015	7	5	2	44	8	0.3	3.9	0.7	94.8	88.084	58.3388
2015	7	5	2	54	8	0.3	3.9	0.73	96.5	88.084	60.256
2015	7	5	3	4	8	0.3	3.9	0.73	95.4	88.1496	61.1249
2015	7	5	3	14	8	0.3	3.9	0.74	95.1	88.1496	61.9472
2015	7	5	3	24	8	0.3	3.9	0.74	94.1	88.1496	61.6731
2015	7	5	3	34	8	0.3	3.9	0.73	95.4	88.1496	60.8509
2015	7	5	3	44	8	0.3	3.9	0.72	96.8	88.1496	60.0286
2015	7	5	3	54	8	0.3	3.9	0.7	95.7	88.1496	57.8357
2015	7	5	4	4	8	0.3	3.9	0.75	96.1	88.1496	61.9473
2015	7	5	4	14	8	0.3	3.9	0.68	97.4	88.2152	56.7832
2015	7	5	4	24	8	0.3	3.9	0.72	93.1	88.2808	60.1213
2015	7	5	4	34	8	0.3	3.9	0.73	96.7	88.2808	60.9449
2015	7	5	4	44	8	0.3	3.9	0.73	95.9	88.3465	60.7172
2015	7	5	4	54	8	0.3	3.9	0.77	97.1	88.4121	63.7884
2015	7	5	5	4	8	0.3	3.9	0.74	96.4	88.4777	61.3611
2015	7	5	5	14	8	0.3	3.9	0.74	95.3	88.4777	61.9114
2015	7	5	5	24	8	0.3	3.9	0.74	96.6	88.4777	61.9114
2015	7	5	5	34	8	0.3	3.9	0.73	94.4	88.4777	61.086
2015	7	5	5	44	8	0.3	3.9	0.73	97.7	88.5433	60.8576

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	5	5	54	8	0.3	3.9	0.73	95.4	88.5433	61.133
2015	7	5	6	4	8	0.3	3.9	0.73	95.4	88.5433	60.8576
2015	7	5	6	14	8	0.3	3.9	0.74	98.2	88.5433	61.133
2015	7	5	6	24	8	0.3	3.9	0.73	95.7	88.5433	60.5823
2015	7	5	6	34	8	0.3	3.9	0.7	94.3	88.5433	58.93
2015	7	5	6	44	8	0.3	3.9	0.74	95.3	88.6089	62.0068
2015	7	5	6	54	8	0.3	3.9	0.73	95.4	88.6089	60.9045
2015	7	5	7	4	8	0.3	3.9	0.75	96.3	88.6089	62.8336
2015	7	5	7	14	8	0.3	3.9	0.74	96.6	88.6089	62.0068
2015	7	5	7	24	8	0.3	3.9	0.72	94.2	88.6089	60.0777
2015	7	5	7	34	8	0.3	3.9	0.73	96.7	88.6089	61.1801
2015	7	5	7	44	8	0.3	3.9	0.73	97.8	88.6089	60.3533
2015	7	5	7	54	8	0.3	3.9	0.76	97.2	88.6089	63.3848
2015	7	5	8	4	8	0.3	3.9	0.74	100.2	88.6745	61.5028
2015	7	5	8	14	8	0.3	3.9	0.75	97	88.6745	62.8818
2015	7	5	8	24	8	0.3	3.9	0.74	97.1	88.6745	62.0544
2015	7	5	8	34	8	0.3	3.9	0.74	96.6	88.6745	61.7786
2015	7	5	8	44	8	0.3	3.9	0.75	96.5	88.6745	62.606
2015	7	5	8	54	8	0.3	3.9	0.74	97.6	88.6745	62.0544
2015	7	5	9	4	8	0.3	3.9	0.7	98.1	88.6745	58.1933
2015	7	5	9	14	8	0.3	3.9	0.73	95.2	88.6745	60.9512
2015	7	5	9	24	8	0.3	3.9	0.75	98	88.6745	62.606
2015	7	5	9	34	8	0.3	3.9	0.76	98.2	88.7402	62.9301
2015	7	5	9	44	8	0.3	3.9	0.78	96.5	88.7402	65.4141
2015	7	5	9	54	8	0.3	3.9	0.74	97.9	88.7402	61.826
2015	7	5	10	4	8	0.3	3.9	0.73	95.7	88.7402	60.7219
2015	7	5	10	14	8	0.3	3.9	0.73	94.4	88.7402	61.274
2015	7	5	10	24	8	0.3	3.9	0.74	97.6	88.7402	62.102
2015	7	5	10	34	8	0.3	3.9	0.78	96.1	88.7402	64.8621
2015	7	5	10	44	8	0.3	3.9	0.77	100.1	88.7402	63.482
2015	7	5	10	54	8	0.3	3.9	0.76	99.7	88.7402	63.206
2015	7	5	11	4	8	0.3	3.9	0.78	99.7	88.7402	64.862
2015	7	5	11	14	8	0.3	3.9	0.76	98.9	88.7402	63.482
2015	7	5	11	24	8	0.3	3.9	0.77	100	88.7402	64.034
2015	7	5	11	34	8	0.3	3.9	0.75	98.8	88.8058	62.1495
2015	7	5	11	44	8	0.3	3.9	0.76	97.4	88.7402	63.4819
2015	7	5	11	54	8	0.3	3.9	0.71	100.9	88.7402	58.5138
2015	7	5	12	4	8	0.3	3.9	0.76	96.9	88.8058	63.8068
2015	7	5	12	14	8	0.3	3.9	0.74	102.3	88.8058	60.7684
2015	7	5	12	24	8	0.3	3.9	0.72	102.1	88.8058	59.1111
2015	7	5	12	34	8	0.3	3.9	0.75	101.6	88.8058	62.1495
2015	7	5	12	44	8	0.3	3.9	0.74	101.6	88.8058	60.7684
2015	7	5	12	54	8	0.3	3.9	0.74	103.3	88.8058	60.7683
2015	7	5	13	4	8	0.3	3.9	0.69	103.8	88.8714	56.392
2015	7	5	13	14	8	0.3	3.9	0.75	102.6	88.8714	61.6442
2015	7	5	13	24	8	0.3	3.9	0.75	101.4	88.8058	61.597
2015	7	5	13	34	8	0.3	3.9	0.68	98.8	88.8058	56.9013

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	5	13	44	8	0.3	3.9	0.7	102.2	88.8714	57.4977
2015	7	5	13	54	8	0.3	3.9	0.75	103.5	88.8714	61.0914
2015	7	5	14	4	8	0.3	3.9	0.75	97.5	88.8714	63.0264
2015	7	5	14	14	8	0.3	3.9	0.73	95.1	88.8714	61.6443
2015	7	5	14	24	8	0.3	3.9	0.75	94.7	88.8714	63.3029
2015	7	5	14	34	8	0.3	3.9	0.71	95.9	88.8714	59.1564
2015	7	5	14	44	8	0.3	3.9	0.77	96.6	88.8714	64.1322
2015	7	5	14	54	8	0.3	3.9	0.75	95.5	88.8714	62.75
2015	7	5	15	4	8	0.3	3.9	0.76	96.4	88.8714	63.5794
2015	7	5	15	14	8	0.3	3.9	0.72	96.5	88.937	60.3083
2015	7	5	15	24	8	0.3	3.9	0.75	93.7	89.0026	63.3999
2015	7	5	15	34	8	0.3	3.9	0.74	94.8	89.0026	62.0156
2015	7	5	15	44	8	0.3	3.9	0.76	97.5	89.0026	63.3999
2015	7	5	15	54	8	0.3	3.9	0.73	92.1	89.0026	61.7387
2015	7	5	16	4	8	0.3	3.9	0.74	96.7	89.0683	61.7859
2015	7	5	16	14	8	0.3	3.9	0.76	96.5	89.0683	63.4483
2015	7	5	16	24	8	0.3	3.9	0.73	95.1	89.0683	61.7859
2015	7	5	16	34	8	0.3	3.9	0.74	95.8	89.0683	62.34
2015	7	5	16	44	8	0.3	3.9	0.75	100.1	89.1339	62.3877
2015	7	5	16	54	8	0.3	3.9	0.75	97.3	89.1339	62.9422
2015	7	5	17	4	8	0.3	3.9	0.73	97.4	89.2651	61.6498
2015	7	5	17	14	8	0.3	3.9	0.76	95.2	89.2651	64.1491
2015	7	5	17	24	8	0.3	3.9	0.74	100	89.2651	61.6498
2015	7	5	17	34	8	0.3	3.9	0.76	96.4	89.2651	63.8714
2015	7	5	17	44	8	0.3	3.9	0.76	100.4	89.2651	63.5937
2015	7	5	17	54	8	0.3	3.9	0.74	97.6	89.2651	62.4829
2015	7	5	18	4	8	0.3	3.9	0.76	100	89.2651	63.316
2015	7	5	18	14	8	0.3	3.9	0.78	98.7	89.2651	64.9822
2015	7	5	18	24	8	0.3	3.9	0.76	96	89.3307	63.6421
2015	7	5	18	34	8	0.3	3.9	0.76	99.1	89.2651	63.8713
2015	7	5	18	44	8	0.3	3.9	0.78	96.8	89.2651	65.2598
2015	7	5	18	54	8	0.3	3.9	0.78	96.3	89.2651	65.5375
2015	7	5	19	4	8	0.3	3.9	0.75	94	89.2651	63.3159
2015	7	5	19	14	8	0.3	3.9	0.72	96.8	89.3307	60.863
2015	7	5	19	24	8	0.3	3.9	0.76	97.4	89.3307	63.92
2015	7	5	19	34	8	0.3	3.9	0.78	96.8	89.3307	65.5875
2015	7	5	19	44	8	0.3	3.9	0.76	96.2	89.3963	64.2468
2015	7	5	19	54	8	0.3	3.9	0.77	93.7	89.3963	65.3593
2015	7	5	20	4	8	0.3	3.9	0.77	97.8	89.462	65.1307
2015	7	5	20	14	8	0.3	3.9	0.76	95.9	89.462	64.2957
2015	7	5	20	24	8	0.3	3.9	0.74	97.6	89.462	62.6257
2015	7	5	20	34	8	0.3	3.9	0.73	95.4	89.462	61.5123
2015	7	5	20	44	8	0.3	3.9	0.72	95.5	89.462	60.9557
2015	7	5	20	54	8	0.3	3.9	0.73	95.7	89.5276	61.8377
2015	7	5	21	4	8	0.3	3.9	0.72	92.6	89.5276	61.2806
2015	7	5	21	14	8	0.3	3.9	0.78	96.8	89.5276	65.4588
2015	7	5	21	24	8	0.3	3.9	0.73	93.9	89.5276	61.5591

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	5	21	34	8	0.3	3.9	0.75	98.3	89.5276	62.9519
2015	7	5	21	44	8	0.3	3.9	0.76	95.2	89.5276	64.6231
2015	7	5	21	54	8	0.3	3.9	0.75	95.2	89.5276	63.7875
2015	7	5	22	4	8	0.3	3.9	0.71	93.7	89.5932	60.2121
2015	7	5	22	14	8	0.3	3.9	0.77	95.9	89.5932	64.6723
2015	7	5	22	24	8	0.3	3.9	0.76	96.7	89.5932	64.3935
2015	7	5	22	34	8	0.3	3.9	0.75	97.7	89.5932	63.5573
2015	7	5	22	44	8	0.3	3.9	0.74	94.1	89.5932	62.4422
2015	7	5	22	54	8	0.3	3.9	0.72	95	89.6588	61.0948
2015	7	5	23	4	8	0.3	3.9	0.79	95.7	89.6588	66.6742
2015	7	5	23	14	8	0.3	3.9	0.71	95.6	89.6588	60.2579
2015	7	5	23	24	8	0.3	3.9	0.77	96.6	89.6588	65.2794
2015	7	5	23	34	8	0.3	3.9	0.75	97.6	89.6588	63.0476
2015	7	5	23	44	8	0.3	3.9	0.76	95.9	89.7244	64.4914
2015	7	5	23	54	8	0.3	3.9	0.75	97.8	89.7244	63.0955
2015	7	6	0	4	8	0.3	3.9	0.77	94.4	89.7244	65.0498
2015	7	6	0	14	8	0.3	3.9	0.77	94.9	89.7244	65.6081
2015	7	6	0	24	8	0.3	3.9	0.76	95.9	89.7244	64.4914
2015	7	6	0	34	8	0.3	3.9	0.74	94.1	89.79	62.5846
2015	7	6	0	44	8	0.3	3.9	0.79	94.3	89.8556	67.1057
2015	7	6	0	54	8	0.3	3.9	0.74	93.3	89.9213	63.2391
2015	7	6	1	4	8	0.3	3.9	0.75	96.3	89.9869	63.2869
2015	7	6	1	14	8	0.3	3.9	0.77	95.6	90.0525	65.857
2015	7	6	1	24	8	0.3	3.9	0.74	94.3	90.0525	62.7743
2015	7	6	1	34	8	0.3	3.9	0.79	95.5	90.0525	67.2582
2015	7	6	1	44	8	0.3	3.9	0.72	93.4	90.0525	61.0929
2015	7	6	1	54	8	0.3	3.9	0.75	95	90.1181	63.9436
2015	7	6	2	4	8	0.3	3.9	0.76	95.5	90.1181	64.5045
2015	7	6	2	14	8	0.3	3.9	0.73	93.8	90.1181	62.5413
2015	7	6	2	24	8	0.3	3.9	0.78	96.3	90.1181	66.1872
2015	7	6	2	34	8	0.3	3.9	0.78	98.5	90.1181	65.9068
2015	7	6	2	44	8	0.3	3.9	0.78	97.3	90.1837	65.9566
2015	7	6	2	54	8	0.3	3.9	0.79	97.4	90.1837	66.7986
2015	7	6	3	4	8	0.3	3.9	0.76	95.4	90.1837	65.1146
2015	7	6	3	14	8	0.3	3.9	0.74	96.1	90.1837	62.8693
2015	7	6	3	24	8	0.3	3.9	0.78	99.2	90.1837	65.9566
2015	7	6	3	34	8	0.3	3.9	0.78	97.5	90.1837	66.2373
2015	7	6	3	44	8	0.3	3.9	0.76	94	90.1837	64.834
2015	7	6	3	54	8	0.3	3.9	0.75	95.5	90.2494	63.7594
2015	7	6	4	4	8	0.3	3.9	0.75	96.8	90.2494	63.7594
2015	7	6	4	14	8	0.3	3.9	0.74	92.5	90.2494	63.1977
2015	7	6	4	24	8	0.3	3.9	0.77	98.1	90.2494	65.4447
2015	7	6	4	34	8	0.3	3.9	0.79	95.3	90.2494	67.13
2015	7	6	4	44	8	0.3	3.9	0.78	96.8	90.2494	66.2874
2015	7	6	4	54	8	0.3	4.3	0.76	97.4	90.315	64.9319
2015	7	6	5	4	8	0.3	4.3	0.75	97	90.315	64.0887
2015	7	6	5	14	8	0.3	4.3	0.74	94.6	90.315	63.2454

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	6	5	24	8	0.3	4.3	0.77	96.2	90.315	65.2131
2015	7	6	5	34	8	0.3	4.3	0.77	97.9	90.315	65.2131
2015	7	6	5	44	8	0.3	4.3	0.74	95.6	90.315	63.2455
2015	7	6	5	54	8	0.3	4.3	0.75	95	90.315	64.3698
2015	7	6	6	4	8	0.3	4.3	0.78	97.2	90.315	66.3375
2015	7	6	6	14	8	0.3	4.3	0.73	95.4	90.315	62.6833
2015	7	6	6	24	8	0.3	4.3	0.78	98	90.3806	65.8249
2015	7	6	6	34	8	0.3	4.3	0.76	95.2	90.3806	64.6997
2015	7	6	6	44	8	0.3	4.3	0.76	95.5	90.3806	64.6997
2015	7	6	6	54	8	0.3	4.3	0.75	93.7	90.3806	64.4184
2015	7	6	7	4	8	0.3	4.3	0.8	94.7	90.3806	68.0754
2015	7	6	7	14	8	0.3	4.3	0.77	96.6	90.3806	65.2624
2015	7	6	7	24	8	0.3	4.3	0.76	95.7	90.3806	64.4184
2015	7	6	7	34	8	0.3	4.3	0.78	95.6	90.4462	66.4375
2015	7	6	7	44	8	0.3	4.3	0.76	96.5	90.4462	64.4669
2015	7	6	7	54	8	0.3	4.3	0.75	96.3	90.4462	64.1854
2015	7	6	8	4	8	0.3	4.3	0.75	99.1	90.5118	63.6703
2015	7	6	8	14	8	0.3	4.3	0.78	97	90.5118	66.2058
2015	7	6	8	24	8	0.3	4.3	0.78	97.2	90.5774	66.5375
2015	7	6	8	34	8	0.3	4.3	0.76	94.2	90.6431	64.8946
2015	7	6	8	44	8	0.3	4.3	0.74	95.1	90.6431	63.2017
2015	7	6	8	54	8	0.3	4.3	0.78	95.8	90.6431	66.3053
2015	7	6	9	4	8	0.3	4.3	0.75	94.3	90.6431	64.0481
2015	7	6	9	14	8	0.3	4.3	0.77	97.9	90.6431	65.4588
2015	7	6	9	24	8	0.3	4.3	0.78	96.8	90.6431	66.5874
2015	7	6	9	34	8	0.3	4.3	0.77	96.2	90.7087	65.5079
2015	7	6	9	44	8	0.3	4.3	0.79	94.8	90.7087	67.4845
2015	7	6	9	54	8	0.3	4.3	0.78	97	90.7087	66.9197
2015	7	6	10	4	8	0.3	4.3	0.79	96.9	90.7087	67.2021
2015	7	6	10	14	8	0.3	4.3	0.8	95.9	90.7087	68.8962
2015	7	6	10	24	8	0.3	4.3	0.78	98.4	90.7087	66.6373
2015	7	6	10	34	8	0.3	4.3	0.79	99.9	90.7087	66.6373
2015	7	6	10	44	8	0.3	4.3	0.77	98.6	90.7087	65.2255
2015	7	6	10	54	8	0.3	4.3	0.81	98.4	90.7087	68.6138
2015	7	6	11	4	8	0.3	4.3	0.79	100.5	90.7087	66.9197
2015	7	6	11	14	8	0.3	4.3	0.78	101.1	90.7087	66.0726
2015	7	6	11	24	8	0.3	4.3	0.79	100.8	90.7087	66.6373
2015	7	6	11	34	8	0.3	4.3	0.76	100.4	90.7087	64.3784
2015	7	6	11	44	8	0.3	4.3	0.76	99.1	90.7087	64.9431
2015	7	6	11	54	8	0.3	4.3	0.8	98	90.7087	68.3314
2015	7	6	12	4	8	0.3	4.3	0.79	100.8	90.7087	66.3549
2015	7	6	12	14	8	0.3	4.3	0.76	98.9	90.7087	64.9431
2015	7	6	12	24	8	0.3	4.3	0.77	99.5	90.7087	65.5078
2015	7	6	12	34	8	0.3	4.3	0.77	100.7	90.7087	65.5078
2015	7	6	12	44	8	0.3	4.3	0.76	101.2	90.7087	64.3783
2015	7	6	12	54	8	0.3	4.3	0.77	99.6	90.7087	64.943
2015	7	6	13	4	8	0.3	4.3	0.76	98.9	90.7087	64.9431

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	6	13	14	8	0.3	4.3	0.78	100.2	90.7087	66.0725
2015	7	6	13	24	8	0.3	4.3	0.78	98.4	90.7087	66.6373
2015	7	6	13	34	8	0.3	4.3	0.8	101.5	90.7743	67.8174
2015	7	6	13	44	8	0.3	4.3	0.78	102.2	90.7087	65.2254
2015	7	6	13	54	8	0.3	4.3	0.78	98.2	90.7743	66.4046
2015	7	6	14	4	8	0.3	4.3	0.8	100	90.7743	67.5349
2015	7	6	14	14	8	0.3	4.3	0.77	100.7	90.7743	65.5569
2015	7	6	14	24	8	0.3	4.3	0.77	102	90.7743	64.9917
2015	7	6	14	34	8	0.3	4.3	0.78	97.8	90.8399	66.4544
2015	7	6	14	44	8	0.3	4.3	0.78	96.1	90.7743	66.4047
2015	7	6	14	54	8	0.3	4.3	0.75	100.4	90.8399	63.3438
2015	7	6	15	4	8	0.3	4.3	0.77	100.7	90.8399	65.6061
2015	7	6	15	14	8	0.3	4.3	0.74	97.9	90.8399	63.061
2015	7	6	15	24	8	0.3	4.3	0.79	96.7	90.8399	67.3028
2015	7	6	15	34	8	0.3	4.3	0.76	94.9	90.9055	65.3722
2015	7	6	15	44	8	0.3	4.3	0.77	101.8	90.8399	64.7577
2015	7	6	15	54	8	0.3	4.3	0.78	99.7	90.9055	66.2212
2015	7	6	16	4	8	0.3	4.3	0.76	97.4	90.9055	65.3722
2015	7	6	16	14	8	0.3	4.3	0.75	96.5	90.9055	64.5232
2015	7	6	16	24	8	0.3	4.3	0.8	96.2	90.9055	68.2021
2015	7	6	16	34	8	0.3	4.3	0.78	95	90.9055	67.3532
2015	7	6	16	44	8	0.3	4.3	0.78	97.8	90.9055	66.5042
2015	7	6	16	54	8	0.3	4.3	0.72	96.8	90.9055	61.9762
2015	7	6	17	4	8	0.3	4.3	0.79	94.8	90.9711	67.6868
2015	7	6	17	14	8	0.3	4.3	0.77	94.1	90.9711	66.5539
2015	7	6	17	24	8	0.3	4.3	0.75	99	90.9711	64.2882
2015	7	6	17	34	8	0.3	4.3	0.77	97.6	90.9711	65.9875
2015	7	6	17	44	8	0.3	4.3	0.79	97.4	90.9711	67.4035
2015	7	6	17	54	8	0.3	4.3	0.82	95.5	90.9711	70.802
2015	7	6	18	4	8	0.3	4.3	0.77	94.4	90.9711	65.9875
2015	7	6	18	14	8	0.3	4.3	0.78	96.8	90.9711	66.8371
2015	7	6	18	24	8	0.3	4.3	0.78	97.7	91.0368	67.1705
2015	7	6	18	34	8	0.3	4.3	0.8	95.9	91.0368	68.871
2015	7	6	18	44	8	0.3	4.3	0.76	96.2	91.0368	65.4699
2015	7	6	18	54	8	0.3	4.3	0.76	96.4	91.0368	65.1865
2015	7	6	19	4	8	0.3	4.3	0.78	97.7	91.0368	67.1704
2015	7	6	19	14	8	0.3	4.3	0.76	94.5	91.0368	65.1865
2015	7	6	19	24	8	0.3	4.3	0.74	95.3	91.0368	63.7694
2015	7	6	19	34	8	0.3	4.3	0.78	95.1	91.1024	66.937
2015	7	6	19	44	8	0.3	4.3	0.77	95.3	91.1024	66.6533
2015	7	6	19	54	8	0.3	4.3	0.77	94.6	91.1024	66.6533
2015	7	6	20	4	8	0.3	4.3	0.78	96.1	91.1024	66.6533
2015	7	6	20	14	8	0.3	4.3	0.8	97.1	91.1024	68.3551
2015	7	6	20	24	8	0.3	4.3	0.75	95	91.1024	64.6679
2015	7	6	20	34	8	0.3	4.3	0.78	96.5	91.168	67.2708
2015	7	6	20	44	8	0.3	4.3	0.77	94.4	91.168	66.7031
2015	7	6	20	54	8	0.3	4.3	0.77	95.3	91.168	66.703

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	6	21	4	8	0.3	4.3	0.78	94.1	91.168	67.2707
2015	7	6	21	14	8	0.3	4.3	0.74	95.1	91.168	63.8646
2015	7	6	21	24	8	0.3	4.3	0.77	95.2	91.168	66.1354
2015	7	6	21	34	8	0.3	4.3	0.76	94.5	91.2336	65.6166
2015	7	6	21	44	8	0.3	4.3	0.77	95.6	91.2336	66.1847
2015	7	6	21	54	8	0.3	4.3	0.76	94.7	91.2992	65.9498
2015	7	6	22	4	8	0.3	4.3	0.8	95.2	91.2336	69.3093
2015	7	6	22	14	8	0.3	4.3	0.79	95.7	91.2336	68.1731
2015	7	6	22	24	8	0.3	4.3	0.76	95.5	91.2992	65.3812
2015	7	6	22	34	8	0.3	4.3	0.76	98.4	91.2992	65.097
2015	7	6	22	44	8	0.3	4.3	0.77	93.2	91.3648	66.8523
2015	7	6	22	54	8	0.3	4.3	0.76	93.2	91.4305	65.4787
2015	7	6	23	4	8	0.3	4.3	0.77	96.9	91.4305	66.3327
2015	7	6	23	14	8	0.3	4.3	0.74	95.6	91.4961	63.818
2015	7	6	23	24	8	0.3	4.3	0.79	96.7	91.4961	68.0915
2015	7	6	23	34	8	0.3	4.3	0.82	98	91.4305	70.6031
2015	7	6	23	44	8	0.3	4.3	0.76	94.9	91.5617	65.8612
2015	7	6	23	54	8	0.3	4.3	0.73	97.4	91.5617	63.2952
2015	7	7	0	4	8	0.3	4.3	0.82	96.4	91.5617	70.7082
2015	7	7	0	14	8	0.3	4.3	0.81	95.4	91.5617	69.8528
2015	7	7	0	24	8	0.3	4.3	0.76	94.5	91.6273	65.9101
2015	7	7	0	34	8	0.3	4.3	0.79	95	91.6273	68.7634
2015	7	7	0	44	8	0.3	4.3	0.78	95	91.6273	67.9074
2015	7	7	0	54	8	0.3	4.3	0.79	94.8	91.6273	68.4781
2015	7	7	1	4	8	0.3	4.3	0.77	95.2	91.6273	66.4808
2015	7	7	1	14	8	0.3	4.3	0.79	98.2	91.6273	67.6221
2015	7	7	1	24	8	0.3	4.3	0.76	97.7	91.6929	65.388
2015	7	7	1	34	8	0.3	4.3	0.76	97.2	91.6929	65.6736
2015	7	7	1	44	8	0.3	4.3	0.8	97.1	91.6929	68.8145
2015	7	7	1	54	8	0.3	4.3	0.78	97.5	91.6929	67.3868
2015	7	7	2	4	8	0.3	4.3	0.79	94.1	91.6929	68.2434
2015	7	7	2	14	8	0.3	4.3	0.81	96.3	91.6929	69.6711
2015	7	7	2	24	8	0.3	4.3	0.78	95.6	91.6929	67.3868
2015	7	7	2	34	8	0.3	4.3	0.76	95.7	91.7585	66.008
2015	7	7	2	44	8	0.3	4.3	0.79	96.7	91.7585	68.0083
2015	7	7	2	54	8	0.3	4.3	0.77	97.3	91.7585	66.8653
2015	7	7	3	4	8	0.3	4.3	0.79	94.5	91.7585	68.5798
2015	7	7	3	14	8	0.3	4.3	0.8	98.5	91.7585	68.5798
2015	7	7	3	24	8	0.3	4.3	0.79	96	91.7585	68.0083
2015	7	7	3	34	8	0.3	4.3	0.77	96.1	91.7585	66.5796
2015	7	7	3	44	8	0.3	4.3	0.82	96.7	91.7585	70.5801
2015	7	7	3	54	8	0.3	4.3	0.73	96.4	91.7585	63.4364
2015	7	7	4	4	8	0.3	4.3	0.77	93.9	91.7585	66.5796
2015	7	7	4	14	8	0.3	4.3	0.78	94.3	91.7585	68.0084
2015	7	7	4	24	8	0.3	4.3	0.79	96	91.7585	68.2941
2015	7	7	4	34	8	0.3	4.3	0.77	96.1	91.7585	66.8654
2015	7	7	4	44	8	0.3	4.3	0.8	96.6	91.7585	68.8656

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	7	4	54	8	0.3	4.3	0.78	95.1	91.7585	67.4369
2015	7	7	5	4	8	0.3	4.3	0.8	96.4	91.7585	69.1514
2015	7	7	5	14	8	0.3	4.3	0.78	96.8	91.8242	67.4869
2015	7	7	5	24	8	0.3	4.3	0.8	95.7	91.8242	69.2027
2015	7	7	5	34	8	0.3	4.3	0.77	96.1	91.8242	66.915
2015	7	7	5	44	8	0.3	4.3	0.8	94.5	91.8242	69.2027
2015	7	7	5	54	8	0.3	4.3	0.79	96	91.8242	68.3449
2015	7	7	6	4	8	0.3	4.3	0.8	94.5	91.8242	69.7747
2015	7	7	6	14	8	0.3	4.3	0.78	95.3	91.8242	67.773
2015	7	7	6	24	8	0.3	4.3	0.79	96	91.8242	68.059
2015	7	7	6	34	8	0.3	4.3	0.8	96.8	91.8242	69.2028
2015	7	7	6	44	8	0.3	4.3	0.75	94.5	91.8898	65.5338
2015	7	7	6	54	8	0.3	4.3	0.79	94.5	91.8898	68.3956
2015	7	7	7	4	8	0.3	4.3	0.82	96.2	91.8898	71.2573
2015	7	7	7	14	8	0.3	4.3	0.81	94.4	91.8898	70.3988
2015	7	7	7	24	8	0.3	4.3	0.8	95.4	91.8898	69.5403
2015	7	7	7	34	8	0.3	4.3	0.78	96.1	91.8898	67.2509
2015	7	7	7	44	8	0.3	4.3	0.77	96.1	91.8898	66.9647
2015	7	7	7	54	8	0.3	4.3	0.76	95.5	91.8898	65.82
2015	7	7	8	4	8	0.3	4.3	0.77	96.9	91.8898	66.6786
2015	7	7	8	14	8	0.3	4.3	0.79	96	91.8898	68.3956
2015	7	7	8	24	8	0.3	4.3	0.78	95.5	91.9554	68.1598
2015	7	7	8	34	8	0.3	4.3	0.8	94.9	91.8898	69.8264
2015	7	7	8	44	8	0.3	4.3	0.8	95.9	91.8898	69.8264
2015	7	7	8	54	8	0.3	4.3	0.79	95.2	91.9554	68.7326
2015	7	7	9	4	8	0.3	4.3	0.78	97.2	91.9554	67.587
2015	7	7	9	14	8	0.3	4.3	0.76	96.5	91.9554	65.5823
2015	7	7	9	24	8	0.3	4.3	0.81	97.4	91.9554	70.1645
2015	7	7	9	34	8	0.3	4.3	0.81	98	91.9554	69.5917
2015	7	7	9	44	8	0.3	4.3	0.8	98.5	91.9554	68.7325
2015	7	7	9	54	8	0.3	4.3	0.83	98.7	91.9554	71.31
2015	7	7	10	4	8	0.3	4.3	0.81	98.9	91.9554	69.5917
2015	7	7	10	14	8	0.3	4.3	0.79	100.8	91.9554	67.8733
2015	7	7	10	24	8	0.3	4.3	0.79	100	91.9554	68.1597
2015	7	7	10	34	8	0.3	4.3	0.78	99.7	91.9554	67.0142
2015	7	7	10	44	8	0.3	4.3	0.8	100.1	91.9554	69.0189
2015	7	7	10	54	8	0.3	4.3	0.81	97	91.9554	70.1644
2015	7	7	11	4	8	0.3	4.3	0.79	100.5	91.9554	67.8733
2015	7	7	11	14	8	0.3	4.3	0.81	99.3	91.9554	69.5916
2015	7	7	11	24	8	0.3	4.3	0.8	98	92.021	69.3565
2015	7	7	11	34	8	0.3	4.3	0.82	95.5	92.0866	71.7022
2015	7	7	11	44	8	0.3	4.3	0.79	96.7	92.021	68.2101
2015	7	7	11	54	8	0.3	4.3	0.76	97.6	92.021	66.2039
2015	7	7	12	4	8	0.3	4.3	0.8	99.5	92.021	68.4966
2015	7	7	12	14	8	0.3	4.3	0.77	100	92.021	66.4904
2015	7	7	12	24	8	0.3	4.3	0.77	94.9	92.1522	67.4498
2015	7	7	12	34	8	0.3	4.3	0.81	96.3	92.021	70.2162

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	7	12	44	8	0.3	4.3	0.77	96.3	92.0866	67.1132
2015	7	7	12	54	8	0.3	4.3	0.81	96.8	92.0866	70.2681
2015	7	7	13	4	8	0.3	4.3	0.77	94.9	92.0866	67.4
2015	7	7	13	14	8	0.3	4.3	0.78	100.6	91.9554	67.014
2015	7	7	13	24	8	0.3	4.3	0.82	97.1	92.021	71.0759
2015	7	7	13	34	8	0.3	4.3	0.79	96.2	92.0866	68.2604
2015	7	7	13	44	8	0.3	4.3	0.78	97	92.021	67.9234
2015	7	7	13	54	8	0.3	4.3	0.79	98.6	92.021	68.4965
2015	7	7	14	4	8	0.3	4.3	0.8	96.6	92.021	69.0697
2015	7	7	14	14	8	0.3	4.3	0.81	98.4	92.021	70.2161
2015	7	7	14	24	8	0.3	4.3	0.77	97.5	92.021	67.0636
2015	7	7	14	34	8	0.3	4.3	0.78	96.3	92.021	67.9233
2015	7	7	14	44	8	0.3	4.3	0.77	95.2	92.021	66.777
2015	7	7	14	54	8	0.3	4.3	0.78	95.5	91.9554	68.1595
2015	7	7	15	4	8	0.3	4.3	0.81	96.8	92.021	69.9295
2015	7	7	15	14	8	0.3	4.3	0.78	95.5	92.021	68.2099
2015	7	7	15	24	8	0.3	4.3	0.8	97.8	92.021	69.0697
2015	7	7	15	34	8	0.3	4.3	0.76	97.6	92.021	66.2038
2015	7	7	15	44	8	0.3	4.3	0.78	95.3	92.1522	68.0237
2015	7	7	15	54	8	0.3	4.3	0.79	95.5	92.021	68.7831
2015	7	7	16	4	8	0.3	4.3	0.81	96	92.021	70.5027
2015	7	7	16	14	8	0.3	4.3	0.79	96.9	92.021	68.7831
2015	7	7	16	24	8	0.3	4.3	0.82	95	92.021	71.3625
2015	7	7	16	34	8	0.3	4.3	0.77	97.3	92.021	66.777
2015	7	7	16	44	8	0.3	4.3	0.81	98.2	92.1522	70.0329
2015	7	7	16	54	8	0.3	4.3	0.78	96.3	91.9554	67.5868
2015	7	7	17	4	8	0.3	4.3	0.78	93.2	92.021	67.6367
2015	7	7	17	14	8	0.3	4.3	0.77	96.3	92.021	67.0636
2015	7	7	17	24	8	0.3	4.3	0.78	98	92.021	67.6368
2015	7	7	17	34	8	0.3	4.3	0.81	97	92.0866	70.268
2015	7	7	17	44	8	0.3	4.3	0.79	99.3	91.9554	68.4459
2015	7	7	17	54	8	0.3	4.3	0.78	97.8	91.9554	67.3004
2015	7	7	18	4	8	0.3	4.3	0.81	96	92.021	70.5027
2015	7	7	18	14	8	0.3	4.3	0.79	97.2	91.9554	68.4459
2015	7	7	18	24	8	0.3	4.3	0.78	95.6	91.9554	67.5868
2015	7	7	18	34	8	0.3	4.3	0.77	97.3	92.021	67.0636
2015	7	7	18	44	8	0.3	4.3	0.79	96	92.021	68.4965
2015	7	7	18	54	8	0.3	4.3	0.82	96.2	92.021	71.6491
2015	7	7	19	4	8	0.3	4.3	0.78	98	91.9554	67.014
2015	7	7	19	14	8	0.3	4.3	0.8	94	91.9554	69.8778
2015	7	7	19	24	8	0.3	4.3	0.8	97.8	91.9554	69.0186
2015	7	7	19	34	8	0.3	4.3	0.81	97.5	91.9554	69.8778
2015	7	7	19	44	8	0.3	4.3	0.8	93.3	92.021	69.3563
2015	7	7	19	54	8	0.3	4.3	0.77	94.9	92.1522	67.4496
2015	7	7	20	4	8	0.3	4.3	0.78	96.1	92.0866	67.3999
2015	7	7	20	14	8	0.3	4.3	0.77	95.2	92.021	66.7769
2015	7	7	20	24	8	0.3	4.3	0.77	97.9	92.021	66.4903

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	7	20	34	8	0.3	4.3	0.76	95.2	92.0866	65.9658
2015	7	7	20	44	8	0.3	4.3	0.77	97.6	92.0866	66.8262
2015	7	7	20	54	8	0.3	4.3	0.82	96.4	92.1522	71.1809
2015	7	7	21	4	8	0.3	4.3	0.76	93.7	92.0866	66.5394
2015	7	7	21	14	8	0.3	4.3	0.78	95.5	92.0866	68.2602
2015	7	7	21	24	8	0.3	4.3	0.81	95.4	92.0866	70.2679
2015	7	7	21	34	8	0.3	4.3	0.75	93.8	92.0866	65.3922
2015	7	7	21	44	8	0.3	4.3	0.78	96	92.1522	67.7366
2015	7	7	21	54	8	0.3	4.3	0.76	96.4	92.1522	66.0145
2015	7	7	22	4	8	0.3	4.3	0.81	97.9	92.1522	70.0327
2015	7	7	22	14	8	0.3	4.3	0.79	94.1	92.2179	68.6483
2015	7	7	22	24	8	0.3	4.3	0.79	93.3	92.2835	69.2738
2015	7	7	22	34	8	0.3	4.3	0.82	95.7	92.2835	71.5733
2015	7	7	22	44	8	0.3	4.3	0.81	93.5	92.2835	70.711
2015	7	7	22	54	8	0.3	4.3	0.78	94.8	92.3491	68.4619
2015	7	7	23	4	8	0.3	4.3	0.78	95.6	92.3491	67.8865
2015	7	7	23	14	8	0.3	4.3	0.79	94.5	92.3491	68.7495
2015	7	7	23	24	8	0.3	4.3	0.78	94.8	92.3491	68.1742
2015	7	7	23	34	8	0.3	4.3	0.78	96.3	92.4147	67.9365
2015	7	7	23	44	8	0.3	4.3	0.78	95.3	92.3491	68.1742
2015	7	7	23	54	8	0.3	4.3	0.77	95.6	92.3491	67.0236
2015	7	8	0	4	8	0.3	4.3	0.79	96.2	92.4147	69.088
2015	7	8	0	14	8	0.3	4.3	0.79	96.9	92.3491	68.7495
2015	7	8	0	24	8	0.3	4.3	0.76	95.7	92.4147	66.4972
2015	7	8	0	34	8	0.3	4.3	0.81	94.4	92.4147	70.5273
2015	7	8	0	44	8	0.3	4.3	0.79	95	92.4147	69.3759
2015	7	8	0	54	8	0.3	4.3	0.75	96	92.4147	65.3457
2015	7	8	1	4	8	0.3	4.3	0.79	95.9	92.4803	69.1389
2015	7	8	1	14	8	0.3	4.3	0.75	93.5	92.4147	65.9215
2015	7	8	1	24	8	0.3	4.3	0.77	92.2	92.4803	67.4104
2015	7	8	1	34	8	0.3	4.3	0.84	96.7	92.4803	73.4601
2015	7	8	1	44	8	0.3	4.3	0.8	94.5	92.4803	70.0031
2015	7	8	1	54	8	0.3	4.3	0.79	96	92.4803	68.8508
2015	7	8	2	4	8	0.3	4.3	0.81	95.8	92.4803	70.5793
2015	7	8	2	14	8	0.3	4.3	0.81	93.5	92.4803	70.5793
2015	7	8	2	24	8	0.3	4.3	0.78	94.4	92.4803	67.9866
2015	7	8	2	34	8	0.3	4.3	0.74	93.8	92.4803	65.1058
2015	7	8	2	44	8	0.3	4.3	0.77	95.6	92.4803	67.1224
2015	7	8	2	54	8	0.3	4.3	0.82	93.4	92.4803	72.0197
2015	7	8	3	4	8	0.3	4.3	0.76	95.7	92.4803	66.5462
2015	7	8	3	14	8	0.3	4.3	0.79	98.1	92.4803	68.8509
2015	7	8	3	24	8	0.3	4.3	0.85	95.1	92.5459	74.3791
2015	7	8	3	34	8	0.3	4.3	0.8	96.8	92.5459	69.7664
2015	7	8	3	44	8	0.3	4.3	0.8	94.7	92.5459	70.343
2015	7	8	3	54	8	0.3	4.3	0.78	96.1	92.5459	67.7484
2015	7	8	4	4	8	0.3	4.3	0.8	95.2	92.5459	70.343
2015	7	8	4	14	8	0.3	4.3	0.78	94.6	92.5459	68.325

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	8	4	24	8	0.3	4.3	0.8	97.1	92.5459	69.4782
2015	7	8	4	34	8	0.3	4.3	0.8	92.4	92.5459	70.0548
2015	7	8	4	44	8	0.3	4.3	0.81	95.8	92.5459	71.208
2015	7	8	4	54	8	0.3	4.3	0.79	94.1	92.5459	68.9016
2015	7	8	5	4	8	0.3	4.3	0.81	97.2	92.5459	70.9197
2015	7	8	5	14	8	0.3	4.3	0.77	93.2	92.5459	67.4602
2015	7	8	5	24	8	0.3	4.3	0.78	97.3	92.5459	67.7485
2015	7	8	5	34	8	0.3	4.3	0.79	97.6	92.5459	69.19
2015	7	8	5	44	8	0.3	4.3	0.77	95.4	92.5459	67.4603
2015	7	8	5	54	8	0.3	4.3	0.79	96.2	92.5459	68.6134
2015	7	8	6	4	8	0.3	4.3	0.8	96.2	92.5459	69.4783
2015	7	8	6	14	8	0.3	4.3	0.81	94	92.5459	70.6315
2015	7	8	6	24	8	0.3	4.3	0.78	97	92.5459	67.7486
2015	7	8	6	34	8	0.3	4.3	0.79	95.9	92.5459	69.4784
2015	7	8	6	44	8	0.3	4.3	0.79	95.2	92.5459	69.1901
2015	7	8	6	54	8	0.3	4.3	0.8	97.3	92.5459	69.4784
2015	7	8	7	4	8	0.3	4.3	0.77	96.1	92.5459	67.4604
2015	7	8	7	14	8	0.3	4.3	0.79	94.5	92.6116	69.241
2015	7	8	7	24	8	0.3	4.3	0.81	95.1	92.6116	70.6835
2015	7	8	7	34	8	0.3	4.3	0.8	96.6	92.6116	70.1065
2015	7	8	7	44	8	0.3	4.3	0.83	96.8	92.6116	72.703
2015	7	8	7	54	8	0.3	4.3	0.8	95.7	92.6116	69.818
2015	7	8	8	4	8	0.3	4.3	0.81	96.8	92.6116	70.395
2015	7	8	8	14	8	0.3	4.3	0.8	98.1	92.6116	69.241
2015	7	8	8	24	8	0.3	4.3	0.82	96.9	92.6116	71.2605
2015	7	8	8	34	8	0.3	4.3	0.79	96	92.6116	68.9524
2015	7	8	8	44	8	0.3	4.3	0.77	94.9	92.6116	67.5099
2015	7	8	8	54	8	0.3	4.3	0.81	96.5	92.6116	70.972
2015	7	8	9	4	8	0.3	4.3	0.76	97.4	92.6116	66.3559
2015	7	8	9	14	8	0.3	4.3	0.81	98.2	92.6116	70.1065
2015	7	8	9	24	8	0.3	4.3	0.8	99.7	92.6116	68.9524
2015	7	8	9	34	8	0.3	4.3	0.85	100	92.6116	73.857
2015	7	8	9	44	8	0.3	4.3	0.82	96.2	92.6116	72.126
2015	7	8	9	54	8	0.3	4.3	0.81	97.7	92.6116	70.3949
2015	7	8	10	4	8	0.3	4.3	0.8	99.2	92.6116	69.2409
2015	7	8	10	14	8	0.3	4.3	0.81	100	92.6116	70.3949
2015	7	8	10	24	8	0.3	4.3	0.82	98.3	92.6116	71.2604
2015	7	8	10	34	8	0.3	4.3	0.8	99.4	92.6116	69.8179
2015	7	8	10	44	8	0.3	4.3	0.82	99.4	92.6116	71.5489
2015	7	8	10	54	8	0.3	4.3	0.82	102.3	92.6116	70.1063
2015	7	8	11	4	8	0.3	4.3	0.84	96.8	92.6116	72.9914
2015	7	8	11	14	8	0.3	4.3	0.83	100.2	92.6116	72.1258
2015	7	8	11	24	8	0.3	4.3	0.83	101	92.6116	71.5488
2015	7	8	11	34	8	0.3	4.3	0.8	101.9	92.6116	68.6638
2015	7	8	11	44	8	0.3	4.3	0.81	99.8	92.6116	69.8178
2015	7	8	11	54	8	0.3	4.3	0.79	97.6	92.6116	69.2408
2015	7	8	12	4	8	0.3	4.3	0.81	96.8	92.6772	70.7352

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	8	12	14	8	0.3	4.3	0.81	97.2	92.6116	70.9717
2015	7	8	12	24	8	0.3	4.3	0.8	100.9	92.6116	68.6637
2015	7	8	12	34	8	0.3	4.3	0.79	98.6	92.6116	68.9522
2015	7	8	12	44	8	0.3	4.3	0.81	98.4	92.6772	70.4464
2015	7	8	12	54	8	0.3	4.3	0.79	102	92.6772	67.8479
2015	7	8	13	4	8	0.3	4.3	0.79	94.5	92.6116	69.2407
2015	7	8	13	14	8	0.3	4.3	0.79	98.6	92.6116	68.9522
2015	7	8	13	24	8	0.3	4.3	0.83	102.2	92.6116	70.9717
2015	7	8	13	34	8	0.3	4.3	0.78	96.6	92.6116	67.7981
2015	7	8	13	44	8	0.3	4.3	0.78	95.8	92.6116	68.3751
2015	7	8	13	54	8	0.3	4.3	0.8	97.7	92.6116	70.1061
2015	7	8	14	4	8	0.3	4.3	0.76	100.2	92.6116	66.0671
2015	7	8	14	14	8	0.3	4.3	0.81	98.4	92.6116	70.3947
2015	7	8	14	24	8	0.3	4.3	0.76	98.9	92.5459	66.0186
2015	7	8	14	34	8	0.3	4.3	0.81	96.3	92.6116	70.6832
2015	7	8	14	44	8	0.3	4.3	0.8	96.4	92.6116	69.8177
2015	7	8	14	54	8	0.3	4.3	0.78	94.4	92.6116	68.0867
2015	7	8	15	4	8	0.3	4.3	0.81	98.4	92.6116	70.3947
2015	7	8	15	14	8	0.3	4.3	0.81	98.9	92.5459	70.0548
2015	7	8	15	24	8	0.3	4.3	0.79	96.4	92.5459	68.9016
2015	7	8	15	34	8	0.3	4.3	0.78	99.1	92.5459	68.0367
2015	7	8	15	44	8	0.3	4.3	0.79	95.5	92.5459	68.9016
2015	7	8	15	54	8	0.3	4.3	0.76	95.4	92.6116	66.9327
2015	7	8	16	4	8	0.3	4.3	0.75	97	92.6772	65.8269
2015	7	8	16	14	8	0.3	4.3	0.82	96.4	92.5459	71.4962
2015	7	8	16	24	8	0.3	4.3	0.8	97.7	92.6116	70.1062
2015	7	8	16	34	8	0.3	4.3	0.78	95.8	92.5459	68.325
2015	7	8	16	44	8	0.3	4.3	0.82	95	92.5459	71.7845
2015	7	8	16	54	8	0.3	4.3	0.79	94.5	92.6116	69.2407
2015	7	8	17	4	8	0.3	4.3	0.8	97	92.5459	70.0547
2015	7	8	17	14	8	0.3	4.3	0.82	98.3	92.5459	71.2079
2015	7	8	17	24	8	0.3	4.3	0.8	98.5	92.4803	69.7152
2015	7	8	17	34	8	0.3	4.3	0.79	95.7	92.5459	68.9016
2015	7	8	17	44	8	0.3	4.3	0.81	95.5	92.5459	71.2079
2015	7	8	17	54	8	0.3	4.3	0.78	94.6	92.5459	68.325
2015	7	8	18	4	8	0.3	4.3	0.78	95.5	92.5459	68.6133
2015	7	8	18	14	8	0.3	4.3	0.83	96.6	92.5459	72.0728
2015	7	8	18	24	8	0.3	4.3	0.82	98.3	92.5459	70.9196
2015	7	8	18	34	8	0.3	4.3	0.79	95.7	92.5459	69.1898
2015	7	8	18	44	8	0.3	4.3	0.84	95	92.5459	73.2259
2015	7	8	18	54	8	0.3	4.3	0.78	96.5	92.5459	68.325
2015	7	8	19	4	8	0.3	4.3	0.8	96.1	92.5459	70.0547
2015	7	8	19	14	8	0.3	4.3	0.8	94.7	92.6116	69.8177
2015	7	8	19	24	8	0.3	4.3	0.74	93.8	92.6116	64.9131
2015	7	8	19	34	8	0.3	4.3	0.8	95.4	92.6116	70.1062
2015	7	8	19	44	8	0.3	4.3	0.79	94.8	92.5459	69.1898
2015	7	8	19	54	8	0.3	4.3	0.78	95.8	92.6116	68.3751

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	8	20	4	8	0.3	4.3	0.76	95.7	92.6772	66.4043
2015	7	8	20	14	8	0.3	4.3	0.76	92.5	92.6772	66.9818
2015	7	8	20	24	8	0.3	4.3	0.79	93.3	92.6116	69.2406
2015	7	8	20	34	8	0.3	4.3	0.8	92.8	92.6116	70.6832
2015	7	8	20	44	8	0.3	4.3	0.78	96.3	92.6116	67.7981
2015	7	8	20	54	8	0.3	4.3	0.76	93.7	92.6116	66.3556
2015	7	8	21	4	8	0.3	4.3	0.8	96.8	92.6116	69.8176
2015	7	8	21	14	8	0.3	4.3	0.78	92.2	92.6116	68.9521
2015	7	8	21	24	8	0.3	4.3	0.77	96.1	92.6772	67.2705
2015	7	8	21	34	8	0.3	4.3	0.8	96.1	92.6772	70.1576
2015	7	8	21	44	8	0.3	4.3	0.79	95	92.6116	69.2406
2015	7	8	21	54	8	0.3	4.3	0.8	94.7	92.6772	69.8689
2015	7	8	22	4	8	0.3	4.3	0.8	93.8	92.6772	70.1576
2015	7	8	22	14	8	0.3	4.3	0.76	94.2	92.6772	66.4043
2015	7	8	22	24	8	0.3	4.3	0.77	97.8	92.6772	67.5592
2015	7	8	22	34	8	0.3	4.3	0.8	96.2	92.6772	69.5802
2015	7	8	22	44	8	0.3	4.3	0.79	92.4	92.6772	69.2915
2015	7	8	22	54	8	0.3	4.3	0.8	95.2	92.6772	69.8689
2015	7	8	23	4	8	0.3	4.3	0.76	95.5	92.6772	66.4043
2015	7	8	23	14	8	0.3	4.3	0.75	94.3	92.7428	65.5863
2015	7	8	23	24	8	0.3	4.3	0.77	93.7	92.7428	67.8977
2015	7	8	23	34	8	0.3	4.3	0.76	94.7	92.7428	66.4531
2015	7	8	23	44	8	0.3	4.3	0.77	94.9	92.7428	67.8977
2015	7	8	23	54	8	0.3	4.3	0.76	94.7	92.6772	66.9818
2015	7	9	0	4	8	0.3	4.3	0.77	93.7	92.7428	67.8977
2015	7	9	0	14	8	0.3	4.3	0.78	93.6	92.7428	68.7645
2015	7	9	0	24	8	0.3	4.3	0.82	93.4	92.8084	72.5737
2015	7	9	0	34	8	0.3	4.3	0.74	94.6	92.7428	65.2974
2015	7	9	0	44	8	0.3	4.3	0.77	95.2	92.7428	67.3199
2015	7	9	0	54	8	0.3	4.3	0.77	94.6	92.7428	67.6089
2015	7	9	1	4	8	0.3	4.3	0.79	96	92.8084	69.1041
2015	7	9	1	14	8	0.3	4.3	0.76	94.2	92.8084	67.0802
2015	7	9	1	24	8	0.3	4.3	0.76	92.7	92.8084	66.5019
2015	7	9	1	34	8	0.3	4.3	0.79	94.5	92.8084	69.6824
2015	7	9	1	44	8	0.3	4.3	0.8	94.9	92.8084	70.2607
2015	7	9	1	54	8	0.3	4.3	0.76	95.2	92.7428	66.4532
2015	7	9	2	4	8	0.3	4.3	0.79	94.1	92.8084	69.1042
2015	7	9	2	14	8	0.3	4.3	0.8	93.8	92.7428	70.4982
2015	7	9	2	24	8	0.3	4.3	0.79	94.5	92.7428	69.0536
2015	7	9	2	34	8	0.3	4.3	0.78	93.2	92.8084	68.2368
2015	7	9	2	44	8	0.3	4.3	0.81	96.1	92.8084	70.5499
2015	7	9	2	54	8	0.3	4.3	0.8	94.9	92.7428	70.2093
2015	7	9	3	4	8	0.3	4.3	0.78	94.8	92.8084	68.2369
2015	7	9	3	14	8	0.3	4.3	0.79	93.6	92.8084	69.1043
2015	7	9	3	24	8	0.3	4.3	0.79	96	92.8084	69.1043
2015	7	9	3	34	8	0.3	4.3	0.76	95.2	92.8084	66.7912
2015	7	9	3	44	8	0.3	4.3	0.81	97.2	92.874	70.6017

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	9	3	54	8	0.3	4.3	0.79	96.5	92.874	68.8656
2015	7	9	4	4	8	0.3	4.3	0.78	97	92.874	67.9976
2015	7	9	4	14	8	0.3	4.3	0.77	95.1	92.9396	67.7578
2015	7	9	4	24	8	0.3	4.3	0.79	95	92.874	69.155
2015	7	9	4	34	8	0.3	4.3	0.78	94.8	92.874	68.8657
2015	7	9	4	44	8	0.3	4.3	0.77	93.9	92.9396	67.4683
2015	7	9	4	54	8	0.3	4.3	0.81	96.8	92.9396	70.6535
2015	7	9	5	4	8	0.3	4.3	0.78	94.8	92.9396	68.9161
2015	7	9	5	14	8	0.3	4.3	0.81	94.4	92.9396	70.9431
2015	7	9	5	24	8	0.3	4.3	0.81	94.4	93.0053	70.995
2015	7	9	5	34	8	0.3	4.3	0.82	95.8	93.0053	71.8643
2015	7	9	5	44	8	0.3	4.3	0.81	96.5	92.9396	70.6536
2015	7	9	5	54	8	0.3	4.3	0.84	95.8	93.0053	74.1826
2015	7	9	6	4	8	0.3	4.3	0.8	94.7	93.0053	70.1257
2015	7	9	6	14	8	0.3	4.3	0.78	96.1	93.0053	68.0973
2015	7	9	6	24	8	0.3	4.3	0.78	95.5	93.0053	68.9666
2015	7	9	6	34	8	0.3	4.3	0.77	91.7	93.0053	68.0973
2015	7	9	6	44	8	0.3	4.3	0.82	94.4	93.0053	72.1542
2015	7	9	6	54	8	0.3	4.3	0.81	97.6	93.0053	71.2849
2015	7	9	7	4	8	0.3	4.3	0.81	97.2	93.0053	71.2849
2015	7	9	7	14	8	0.3	4.3	0.81	95.1	93.0053	71.5747
2015	7	9	7	24	8	0.3	4.3	0.78	94.8	93.0053	68.9667
2015	7	9	7	34	8	0.3	4.3	0.81	95.1	93.0053	71.5747
2015	7	9	7	44	8	0.3	4.3	0.82	96.2	93.0053	71.5747
2015	7	9	7	54	8	0.3	4.3	0.82	96.7	93.0053	71.5747
2015	7	9	8	4	8	0.3	4.3	0.81	95.6	93.0053	70.9951
2015	7	9	8	14	8	0.3	4.3	0.81	97.6	93.0053	71.2849
2015	7	9	8	24	8	0.3	4.3	0.81	95.8	93.0053	71.5747
2015	7	9	8	34	8	0.3	4.3	0.81	97.2	92.9396	70.6537
2015	7	9	8	44	8	0.3	4.3	0.83	95.9	93.0053	72.7338
2015	7	9	8	54	8	0.3	4.3	0.79	97.6	93.0053	69.5463
2015	7	9	9	4	8	0.3	4.3	0.79	98.6	92.9396	68.6267
2015	7	9	9	14	8	0.3	4.3	0.79	98.4	92.9396	68.6267
2015	7	9	9	24	8	0.3	4.3	0.82	98.3	93.0053	71.2849
2015	7	9	9	34	8	0.3	4.3	0.79	100.8	92.9396	68.3371
2015	7	9	9	44	8	0.3	4.3	0.83	97.7	93.0053	72.444
2015	7	9	9	54	8	0.3	4.3	0.85	100	93.0053	73.6031
2015	7	9	10	4	8	0.3	4.3	0.82	99.7	93.0053	70.9951
2015	7	9	10	14	8	0.3	4.3	0.83	98.7	93.0053	72.1542
2015	7	9	10	24	8	0.3	4.3	0.81	100.8	92.9396	70.0746
2015	7	9	10	34	8	0.3	4.3	0.79	97.6	93.0053	69.5463
2015	7	9	10	44	8	0.3	4.3	0.81	97	92.9396	70.9433
2015	7	9	10	54	8	0.3	4.3	0.81	94.9	92.9396	71.5224
2015	7	9	11	4	8	0.3	4.3	0.81	94.7	92.9396	70.9433
2015	7	9	11	14	8	0.3	4.3	0.8	96.4	92.9396	70.0746
2015	7	9	11	24	8	0.3	4.3	0.8	95.9	92.9396	70.0746
2015	7	9	11	34	8	0.3	4.3	0.79	97.4	92.9396	69.2059

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	9	11	44	8	0.3	4.3	0.78	96.5	92.9396	68.3372
2015	7	9	11	54	8	0.3	4.3	0.8	95.6	92.874	70.3127
2015	7	9	12	4	8	0.3	4.3	0.78	97	92.9396	68.0477
2015	7	9	12	14	8	0.3	4.3	0.76	93.9	92.9396	67.179
2015	7	9	12	24	8	0.3	4.3	0.78	97.5	93.0053	68.6771
2015	7	9	12	34	8	0.3	4.3	0.78	97	92.9396	68.3373
2015	7	9	12	44	8	0.3	4.3	0.8	95.4	93.0053	70.7055
2015	7	9	12	54	8	0.3	4.3	0.81	96.7	93.0053	71.2851
2015	7	9	13	4	8	0.3	4.3	0.8	95.9	93.0053	70.7055
2015	7	9	13	14	8	0.3	4.3	0.8	93.8	93.0053	70.7055
2015	7	9	13	24	8	0.3	4.3	0.78	95.8	93.0053	68.9668
2015	7	9	13	34	8	0.3	4.3	0.82	95.7	93.0053	72.4442
2015	7	9	13	44	8	0.3	4.3	0.79	95.9	93.0053	69.8362
2015	7	9	13	54	8	0.3	4.3	0.79	95.2	93.0053	69.5464
2015	7	9	14	4	8	0.3	4.3	0.78	96	93.0053	68.6771
2015	7	9	14	14	8	0.3	4.3	0.82	93.9	93.0053	71.8646
2015	7	9	14	24	8	0.3	4.3	0.78	94.6	93.0053	68.9668
2015	7	9	14	34	8	0.3	4.3	0.8	97	93.0053	70.4156
2015	7	9	14	44	8	0.3	4.3	0.79	94.5	92.9396	69.785
2015	7	9	14	54	8	0.3	4.3	0.81	95.1	93.0053	70.9951
2015	7	9	15	4	8	0.3	4.3	0.8	96.8	93.0053	70.4156
2015	7	9	15	14	8	0.3	4.3	0.8	95.9	93.0053	70.1258
2015	7	9	15	24	8	0.3	4.3	0.79	94.5	92.9396	69.4955
2015	7	9	15	34	8	0.3	4.3	0.83	96.6	92.9396	72.3911
2015	7	9	15	44	8	0.3	4.3	0.79	94.1	92.9396	69.4955
2015	7	9	15	54	8	0.3	4.3	0.82	95.5	93.0053	71.8646
2015	7	9	16	4	8	0.3	4.3	0.78	96	93.0053	68.3873
2015	7	9	16	14	8	0.3	4.3	0.8	95.2	92.9396	70.3642
2015	7	9	16	24	8	0.3	4.3	0.81	94.4	92.9396	70.9433
2015	7	9	16	34	8	0.3	4.3	0.8	95	92.9396	70.0747
2015	7	9	16	44	8	0.3	4.3	0.8	96.3	92.9396	70.3642
2015	7	9	16	54	8	0.3	4.3	0.8	98.1	92.9396	69.4956
2015	7	9	17	4	8	0.3	4.3	0.8	96.1	92.9396	70.0747
2015	7	9	17	14	8	0.3	4.3	0.79	95.7	92.9396	69.4956
2015	7	9	17	24	8	0.3	4.3	0.78	93.9	92.9396	68.6269
2015	7	9	17	34	8	0.3	4.3	0.81	95.8	92.9396	70.9434
2015	7	9	17	44	8	0.3	4.3	0.78	97.2	92.9396	68.6269
2015	7	9	17	54	8	0.3	4.3	0.81	95.8	92.9396	71.2329
2015	7	9	18	4	8	0.3	4.3	0.81	96.5	92.9396	71.2329
2015	7	9	18	14	8	0.3	4.3	0.78	94.6	92.9396	68.9164
2015	7	9	18	24	8	0.3	4.3	0.83	97.7	92.9396	72.6808
2015	7	9	18	34	8	0.3	4.3	0.81	96	92.9396	71.2329
2015	7	9	18	44	8	0.3	4.3	0.82	96.7	92.9396	71.5225
2015	7	9	18	54	8	0.3	4.3	0.81	97.7	92.9396	70.6538
2015	7	9	19	4	8	0.3	4.3	0.82	95.5	92.9396	71.8121
2015	7	9	19	14	8	0.3	4.3	0.81	93	92.9396	71.233
2015	7	9	19	24	8	0.3	4.3	0.82	97.4	92.9396	71.8121

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	9	19	34	8	0.3	4.3	0.81	95.8	92.9396	71.233
2015	7	9	19	44	8	0.3	4.3	0.81	95.8	92.9396	71.233
2015	7	9	19	54	8	0.3	4.3	0.81	96.7	92.9396	71.233
2015	7	9	20	4	8	0.3	4.3	0.82	96.2	92.9396	71.8121
2015	7	9	20	14	8	0.3	4.3	0.81	96.3	92.9396	71.233
2015	7	9	20	24	8	0.3	4.3	0.8	93.8	92.9396	70.0747
2015	7	9	20	34	8	0.3	4.3	0.78	96	92.9396	68.3374
2015	7	9	20	44	8	0.3	4.3	0.76	94.2	93.0053	67.2283
2015	7	9	20	54	8	0.3	4.3	0.8	96.3	93.0053	70.4158
2015	7	9	21	4	8	0.3	4.3	0.8	98.5	92.9396	70.0748
2015	7	9	21	14	8	0.3	4.3	0.81	96	93.0053	71.5749
2015	7	9	21	24	8	0.3	4.3	0.82	95	93.0053	72.4443
2015	7	9	21	34	8	0.3	4.3	0.81	95.8	93.0053	71.2852
2015	7	9	21	44	8	0.3	4.3	0.79	97.1	93.0053	69.5465
2015	7	9	21	54	8	0.3	4.3	0.79	96.9	93.0053	69.5465
2015	7	9	22	4	8	0.3	4.3	0.81	94.9	93.0053	71.2852
2015	7	9	22	14	8	0.3	4.3	0.81	94.2	93.0053	71.2852
2015	7	9	22	24	8	0.3	4.3	0.78	95.1	93.0053	68.3874
2015	7	9	22	34	8	0.3	4.3	0.81	98.2	93.0053	70.4159
2015	7	9	22	44	8	0.3	4.3	0.82	93.4	93.0053	72.7341
2015	7	9	22	54	8	0.3	4.3	0.81	95.1	93.0053	71.2852
2015	7	9	23	4	8	0.3	4.3	0.82	96.7	93.0053	71.8648
2015	7	9	23	14	8	0.3	4.3	0.82	95.8	93.0053	71.8648
2015	7	9	23	24	8	0.3	4.3	0.84	95.2	93.0709	73.6572
2015	7	9	23	34	8	0.3	4.3	0.8	94.9	93.0053	70.7057
2015	7	9	23	44	8	0.3	4.3	0.81	94.7	93.0709	71.0473
2015	7	9	23	54	8	0.3	4.3	0.8	97.1	93.0709	69.8874
2015	7	10	0	4	8	0.3	4.3	0.78	95.8	93.0709	69.0175
2015	7	10	0	14	8	0.3	4.3	0.77	95.3	93.0709	68.1475
2015	7	10	0	24	8	0.3	4.3	0.83	96.3	93.0709	73.0773
2015	7	10	0	34	8	0.3	4.3	0.81	95.5	93.0709	71.6274
2015	7	10	0	44	8	0.3	4.3	0.81	95.1	93.0709	71.3374
2015	7	10	0	54	8	0.3	4.3	0.82	94.1	93.0709	72.2074
2015	7	10	1	4	8	0.3	4.3	0.82	94.4	93.0709	71.9174
2015	7	10	1	14	8	0.3	4.3	0.82	95.5	93.0709	72.4974
2015	7	10	1	24	8	0.3	4.3	0.82	96.2	93.0709	71.9174
2015	7	10	1	34	8	0.3	4.3	0.79	96.2	93.0709	69.3075
2015	7	10	1	44	8	0.3	4.3	0.81	94.7	93.0709	71.0475
2015	7	10	1	54	8	0.3	4.3	0.79	95	93.0709	69.5976
2015	7	10	2	4	8	0.3	4.3	0.81	97	93.0709	71.0475
2015	7	10	2	14	8	0.3	4.3	0.79	95.2	93.0709	69.8876
2015	7	10	2	24	8	0.3	4.3	0.78	94.8	93.0709	68.7276
2015	7	10	2	34	8	0.3	4.3	0.79	95.2	93.0709	69.8876
2015	7	10	2	44	8	0.3	4.3	0.78	94.8	93.0709	69.0176
2015	7	10	2	54	8	0.3	4.3	0.77	96.1	93.0709	67.8577
2015	7	10	3	4	8	0.3	4.3	0.78	91.9	93.0709	68.7277
2015	7	10	3	14	8	0.3	4.3	0.8	94.5	93.0709	70.4677

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	10	3	24	8	0.3	4.3	0.8	96.1	93.0709	70.1777
2015	7	10	3	34	8	0.3	4.3	0.8	97.3	93.0709	70.1777
2015	7	10	3	44	8	0.3	4.3	0.81	97.4	93.0709	71.3377
2015	7	10	3	54	8	0.3	4.3	0.77	96.1	93.0709	67.8578
2015	7	10	4	4	8	0.3	4.3	0.78	96.3	93.0709	68.7278
2015	7	10	4	14	8	0.3	4.3	0.8	94.5	93.0709	70.1778
2015	7	10	4	24	8	0.3	4.3	0.83	96.6	93.0709	72.4977
2015	7	10	4	34	8	0.3	4.3	0.78	94.6	93.0709	69.0178
2015	7	10	4	44	8	0.3	4.3	0.79	96	93.0709	69.3078
2015	7	10	4	54	8	0.3	4.3	0.77	94.7	93.0709	67.5679
2015	7	10	5	4	8	0.3	4.3	0.79	96.7	93.0709	69.3079
2015	7	10	5	14	8	0.3	4.3	0.79	98.6	93.0709	69.0179
2015	7	10	5	24	8	0.3	4.3	0.78	95.8	93.0709	69.0179
2015	7	10	5	34	8	0.3	4.3	0.83	95.5	93.0709	72.7878
2015	7	10	5	44	8	0.3	4.3	0.78	95.1	93.0709	68.728
2015	7	10	5	54	8	0.3	4.3	0.82	95.1	93.0709	71.9179
2015	7	10	6	4	8	0.3	4.3	0.77	95.4	93.0709	67.858
2015	7	10	6	14	8	0.3	4.3	0.84	97.2	93.0709	73.3679
2015	7	10	6	24	8	0.3	4.3	0.82	94.3	93.0709	72.4979
2015	7	10	6	34	8	0.3	4.3	0.8	95.4	93.0709	70.178
2015	7	10	6	44	8	0.3	4.3	0.78	94.6	93.0709	69.0181
2015	7	10	6	54	8	0.3	4.3	0.81	95.8	93.0709	71.338
2015	7	10	7	4	8	0.3	4.3	0.83	94.1	93.0709	73.368
2015	7	10	7	14	8	0.3	4.3	0.8	96.8	93.0709	70.4681
2015	7	10	7	24	8	0.3	4.3	0.79	94.3	93.0709	69.3081
2015	7	10	7	34	8	0.3	4.3	0.82	94.1	93.0709	72.498
2015	7	10	7	44	8	0.3	4.3	0.8	98.5	93.0709	69.5981
2015	7	10	7	54	8	0.3	4.3	0.8	96.8	93.0709	70.1781
2015	7	10	8	4	8	0.3	4.3	0.79	98.1	93.0709	69.0181
2015	7	10	8	14	8	0.3	4.3	0.77	94.9	93.0709	67.8581
2015	7	10	8	24	8	0.3	4.3	0.81	96.5	93.0709	71.048
2015	7	10	8	34	8	0.3	4.3	0.81	94.6	93.0709	71.338
2015	7	10	8	44	8	0.3	4.3	0.79	95.7	93.0709	69.5981
2015	7	10	8	54	8	0.3	4.3	0.85	97.6	93.0709	74.2379
2015	7	10	9	4	8	0.3	4.3	0.8	95.6	93.0709	70.468
2015	7	10	9	14	8	0.3	4.3	0.83	97.5	93.0709	73.0779
2015	7	10	9	24	8	0.3	4.3	0.84	97.7	93.0709	73.3679
2015	7	10	9	34	8	0.3	4.3	0.8	97.7	93.0709	70.468
2015	7	10	9	44	8	0.3	4.3	0.82	97.8	93.0709	71.628
2015	7	10	9	54	8	0.3	4.3	0.81	96.5	93.0709	71.048
2015	7	10	10	4	8	0.3	4.3	0.81	101.2	93.0709	70.468
2015	7	10	10	14	8	0.3	4.3	0.82	97.8	93.0709	72.2079
2015	7	10	10	24	8	0.3	4.3	0.81	98.8	93.0709	71.048
2015	7	10	10	34	8	0.3	4.3	0.82	98.9	93.0709	71.9179
2015	7	10	10	44	8	0.3	4.3	0.8	98.9	93.0709	70.178
2015	7	10	10	54	8	0.3	4.3	0.84	97.8	93.0709	73.6578
2015	7	10	11	4	8	0.3	4.3	0.79	100.5	93.0709	69.018

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	10	11	14	8	0.3	4.3	0.82	98.9	93.0709	71.9179
2015	7	10	11	24	8	0.3	4.3	0.81	101.2	93.0709	70.1779
2015	7	10	11	34	8	0.3	4.3	0.8	102.1	93.0709	69.0179
2015	7	10	11	44	8	0.3	4.3	0.81	96.7	93.0053	71.2858
2015	7	10	11	54	8	0.3	4.3	0.82	98.9	93.0053	71.8653
2015	7	10	12	4	8	0.3	4.3	0.81	100.5	93.0053	70.4164
2015	7	10	12	14	8	0.3	4.3	0.83	101.2	93.0053	71.8653
2015	7	10	12	24	8	0.3	4.3	0.8	96.8	93.0709	70.1778
2015	7	10	12	34	8	0.3	4.3	0.82	100.5	93.0053	71.5755
2015	7	10	12	44	8	0.3	4.3	0.84	99	93.0709	73.3677
2015	7	10	12	54	8	0.3	4.3	0.81	97.4	93.0709	71.3378
2015	7	10	13	4	8	0.3	4.3	0.83	102.4	93.0053	71.2857
2015	7	10	13	14	8	0.3	4.3	0.79	98.8	93.0053	69.2572
2015	7	10	13	24	8	0.3	4.3	0.82	95.8	93.0053	71.8653
2015	7	10	13	34	8	0.3	4.3	0.81	100.3	92.9396	70.0754
2015	7	10	13	44	8	0.3	4.3	0.81	97.2	93.0053	70.9959
2015	7	10	13	54	8	0.3	4.3	0.8	100.7	93.0053	69.2573
2015	7	10	14	4	8	0.3	4.3	0.83	100.5	92.9396	71.8128
2015	7	10	14	14	8	0.3	4.3	0.81	100	92.9396	70.365
2015	7	10	14	24	8	0.3	4.3	0.81	98.2	93.0053	70.7062
2015	7	10	14	34	8	0.3	4.3	0.81	97.4	92.9396	71.2337
2015	7	10	14	44	8	0.3	4.3	0.84	99.4	93.0053	73.3143
2015	7	10	14	54	8	0.3	4.3	0.81	96.8	93.0053	70.7062
2015	7	10	15	4	8	0.3	4.3	0.82	100.4	92.9396	71.2337
2015	7	10	15	14	8	0.3	4.3	0.81	99.6	92.9396	70.365
2015	7	10	15	24	8	0.3	4.3	0.8	100.4	92.9396	69.2067
2015	7	10	15	34	8	0.3	4.3	0.8	100.6	92.9396	69.7859
2015	7	10	15	44	8	0.3	4.3	0.82	97.4	92.9396	71.8129
2015	7	10	15	54	8	0.3	4.3	0.79	97.2	92.9396	68.9172
2015	7	10	16	4	8	0.3	4.3	0.83	98.2	92.9396	72.392
2015	7	10	16	14	8	0.3	4.3	0.8	95.7	92.9396	70.0755
2015	7	10	16	24	8	0.3	4.3	0.79	97.7	93.0053	68.9676
2015	7	10	16	34	8	0.3	4.3	0.81	97.5	92.9396	70.6546
2015	7	10	16	44	8	0.3	4.3	0.77	93.4	92.9396	67.4694
2015	7	10	16	54	8	0.3	4.3	0.8	95.9	92.9396	70.365
2015	7	10	17	4	8	0.3	4.3	0.8	96.6	92.9396	70.365
2015	7	10	17	14	8	0.3	4.3	0.8	95.6	92.9396	70.365
2015	7	10	17	24	8	0.3	4.3	0.78	93.6	92.9396	68.9172
2015	7	10	17	34	8	0.3	4.3	0.79	95	92.9396	69.4963
2015	7	10	17	44	8	0.3	4.3	0.79	96	93.0053	68.9676
2015	7	10	17	54	8	0.3	4.3	0.79	95	92.9396	69.4963
2015	7	10	18	4	8	0.3	4.3	0.79	96.7	92.9396	69.4963
2015	7	10	18	14	8	0.3	4.3	0.79	95.7	92.9396	69.2067
2015	7	10	18	24	8	0.3	4.3	0.81	96.5	92.9396	70.9441
2015	7	10	18	34	8	0.3	4.3	0.77	93.7	92.9396	68.0484
2015	7	10	18	44	8	0.3	4.3	0.78	95.3	92.9396	68.338
2015	7	10	18	54	8	0.3	4.3	0.81	97	92.9396	70.6545

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	10	19	4	8	0.3	4.3	0.83	96.3	92.9396	72.9711
2015	7	10	19	14	8	0.3	4.3	0.82	96.7	92.9396	71.5232
2015	7	10	19	24	8	0.3	4.3	0.8	96.6	92.9396	70.0754
2015	7	10	19	34	8	0.3	4.3	0.8	94.5	92.9396	70.0754
2015	7	10	19	44	8	0.3	4.3	0.84	95.8	92.9396	73.8398
2015	7	10	19	54	8	0.3	4.3	0.83	95.4	92.9396	72.9711
2015	7	10	20	4	8	0.3	4.3	0.81	94.9	92.9396	71.5232
2015	7	10	20	14	8	0.3	4.3	0.78	95.8	92.9396	68.338
2015	7	10	20	24	8	0.3	4.3	0.8	96.6	92.9396	70.0754
2015	7	10	20	34	8	0.3	4.3	0.82	96.6	92.9396	72.1023
2015	7	10	20	44	8	0.3	4.3	0.79	94.5	92.9396	69.4962
2015	7	10	20	54	8	0.3	4.3	0.84	95.2	92.9396	73.5502
2015	7	10	21	4	8	0.3	4.3	0.8	95.6	92.9396	70.3649
2015	7	10	21	14	8	0.3	4.3	0.8	96.8	92.9396	70.3649
2015	7	10	21	24	8	0.3	4.3	0.8	94.3	93.0053	70.1266
2015	7	10	21	34	8	0.3	4.3	0.77	95.9	92.9396	67.7588
2015	7	10	21	44	8	0.3	4.3	0.8	96.3	92.9396	70.3649
2015	7	10	21	54	8	0.3	4.3	0.8	98	92.9396	70.0754
2015	7	10	22	4	8	0.3	4.3	0.8	96.3	93.0053	70.4164
2015	7	10	22	14	8	0.3	4.3	0.78	94.8	92.9396	68.6275
2015	7	10	22	24	8	0.3	4.3	0.8	94.9	92.9396	70.365
2015	7	10	22	34	8	0.3	4.3	0.84	96.3	92.9396	73.5502
2015	7	10	22	44	8	0.3	4.3	0.8	95	92.9396	70.0754
2015	7	10	22	54	8	0.3	4.3	0.8	94.5	92.9396	70.365
2015	7	10	23	4	8	0.3	4.3	0.82	94.1	92.9396	72.1024
2015	7	10	23	14	8	0.3	4.3	0.79	95	92.9396	69.4963
2015	7	10	23	24	8	0.3	4.3	0.77	97.8	92.9396	67.4693
2015	7	10	23	34	8	0.3	4.3	0.82	96.5	93.0053	71.5756
2015	7	10	23	44	8	0.3	4.3	0.79	95.7	92.9396	69.2068
2015	7	10	23	54	8	0.3	4.3	0.8	94.7	92.9396	70.365
2015	7	11	0	4	8	0.3	4.3	0.81	96.5	92.9396	70.9442
2015	7	11	0	14	8	0.3	4.3	0.78	95	92.9396	68.9172
2015	7	11	0	24	8	0.3	4.3	0.8	98.9	92.9396	70.0755
2015	7	11	0	34	8	0.3	4.3	0.8	95.4	92.9396	70.3651
2015	7	11	0	44	8	0.3	4.3	0.81	94.2	92.9396	70.9442
2015	7	11	0	54	8	0.3	4.3	0.82	96.5	92.9396	71.5234
2015	7	11	1	4	8	0.3	4.3	0.77	95.1	92.9396	68.0486
2015	7	11	1	14	8	0.3	4.3	0.8	95.7	92.9396	70.0756
2015	7	11	1	24	8	0.3	4.3	0.83	95.9	92.9396	73.2608
2015	7	11	1	34	8	0.3	4.3	0.81	97.7	92.9396	70.9443
2015	7	11	1	44	8	0.3	4.3	0.77	96.6	92.9396	67.7591
2015	7	11	1	54	8	0.3	4.3	0.8	94.5	92.9396	70.3652
2015	7	11	2	4	8	0.3	4.3	0.79	95.7	92.9396	69.4965
2015	7	11	2	14	8	0.3	4.3	0.79	94.7	92.9396	69.7861
2015	7	11	2	24	8	0.3	4.3	0.79	95.7	92.9396	69.4965
2015	7	11	2	34	8	0.3	4.3	0.8	94	92.9396	70.6548
2015	7	11	2	44	8	0.3	4.3	0.82	95.5	92.9396	71.8131

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	11	2	54	8	0.3	4.3	0.78	97.5	92.9396	68.6279
2015	7	11	3	4	8	0.3	4.3	0.83	95.9	92.9396	72.9714
2015	7	11	3	14	8	0.3	4.3	0.81	96.3	92.9396	71.234
2015	7	11	3	24	8	0.3	4.3	0.81	96.1	92.9396	70.9445
2015	7	11	3	34	8	0.3	4.3	0.78	96.8	92.9396	68.0488
2015	7	11	3	44	8	0.3	4.3	0.79	95.3	92.9396	69.2071
2015	7	11	3	54	8	0.3	4.3	0.79	95.5	92.9396	69.4966
2015	7	11	4	4	8	0.3	4.3	0.81	93.9	92.9396	71.5237
2015	7	11	4	14	8	0.3	4.3	0.8	95.2	92.9396	70.0758
2015	7	11	4	24	8	0.3	4.3	0.8	94.9	92.9396	70.3654
2015	7	11	4	34	8	0.3	4.3	0.81	95.6	92.9396	70.9446
2015	7	11	4	44	8	0.3	4.3	0.83	98.4	92.874	72.6288
2015	7	11	4	54	8	0.3	4.3	0.8	95.7	92.874	70.0246
2015	7	11	5	4	8	0.3	4.3	0.82	94.6	92.9396	72.1029
2015	7	11	5	14	8	0.3	4.3	0.78	94.6	92.874	68.2885
2015	7	11	5	24	8	0.3	4.3	0.8	96.8	92.874	70.0247
2015	7	11	5	34	8	0.3	4.3	0.82	96.6	92.874	72.0502
2015	7	11	5	44	8	0.3	4.3	0.79	96.9	92.874	68.8673
2015	7	11	5	54	8	0.3	4.3	0.8	96.8	92.874	70.3141
2015	7	11	6	4	8	0.3	4.3	0.83	96.8	92.874	72.9183
2015	7	11	6	14	8	0.3	4.3	0.81	97	92.874	71.1822
2015	7	11	6	24	8	0.3	4.3	0.81	95.8	92.874	71.4716
2015	7	11	6	34	8	0.3	4.3	0.81	96.1	92.874	70.8929
2015	7	11	6	44	8	0.3	4.3	0.81	98	92.874	70.3142
2015	7	11	6	54	8	0.3	4.3	0.79	94	92.874	69.7355
2015	7	11	7	4	8	0.3	4.3	0.8	96.8	92.874	70.0248
2015	7	11	7	14	8	0.3	4.3	0.81	96.5	92.874	71.1823
2015	7	11	7	24	8	0.3	4.3	0.82	96.4	92.874	71.761
2015	7	11	7	34	8	0.3	4.3	0.83	95.5	92.874	72.6291
2015	7	11	7	44	8	0.3	4.3	0.78	95.8	92.874	68.578
2015	7	11	7	54	8	0.3	4.3	0.79	97.2	92.874	69.1567
2015	7	11	8	4	8	0.3	4.3	0.79	94.3	92.874	69.7355
2015	7	11	8	14	8	0.3	4.3	0.8	96.8	92.874	70.3142
2015	7	11	8	24	8	0.3	4.3	0.79	96.2	92.874	69.4461
2015	7	11	8	34	8	0.3	4.3	0.77	95.1	92.874	67.9993
2015	7	11	8	44	8	0.3	4.3	0.8	96.4	92.8084	69.9735
2015	7	11	8	54	8	0.3	4.3	0.82	96	92.8084	71.7084
2015	7	11	9	4	8	0.3	4.3	0.8	96.6	92.874	69.7354
2015	7	11	9	14	8	0.3	4.3	0.81	96.5	92.8084	70.8409
2015	7	11	9	24	8	0.3	4.3	0.8	96.9	92.8084	69.6843
2015	7	11	9	34	8	0.3	4.3	0.81	96.3	92.8084	71.1301
2015	7	11	9	44	8	0.3	4.3	0.83	97.7	92.8084	72.2866
2015	7	11	9	54	8	0.3	4.3	0.79	97.2	92.8084	69.106
2015	7	11	10	4	8	0.3	4.3	0.84	99.2	92.8084	73.1541
2015	7	11	10	14	8	0.3	4.3	0.81	97	92.8084	71.13
2015	7	11	10	24	8	0.3	4.3	0.81	95.1	92.8084	71.13
2015	7	11	10	34	8	0.3	4.3	0.82	99.5	92.8084	71.13

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	11	10	44	8	0.3	4.3	0.81	96.8	92.8084	70.8408
2015	7	11	10	54	8	0.3	4.3	0.77	102	92.8084	66.7928
2015	7	11	11	4	8	0.3	4.3	0.81	101	92.8084	69.6842
2015	7	11	11	14	8	0.3	4.3	0.82	102.7	92.7428	70.7889
2015	7	11	11	24	8	0.3	4.3	0.8	99	92.7428	69.6331
2015	7	11	11	34	8	0.3	4.3	0.77	100.3	92.7428	67.0327
2015	7	11	11	44	8	0.3	4.3	0.79	100.5	92.7428	68.7663
2015	7	11	11	54	8	0.3	4.3	0.8	102.1	92.7428	68.7663
2015	7	11	12	4	8	0.3	4.3	0.81	96.3	92.6772	70.4482
2015	7	11	12	14	8	0.3	4.3	0.82	101.9	92.6772	71.0256
2015	7	11	12	24	8	0.3	4.3	0.81	101.4	92.6772	70.1595
2015	7	11	12	34	8	0.3	4.3	0.8	103	92.6772	69.0046
2015	7	11	12	44	8	0.3	4.3	0.8	101.5	92.6116	69.2425
2015	7	11	12	54	8	0.3	4.3	0.81	100.5	92.6116	69.8195
2015	7	11	13	4	8	0.3	4.3	0.81	102.2	92.6116	69.5309
2015	7	11	13	14	8	0.3	4.3	0.78	97.7	92.6116	68.3769
2015	7	11	13	24	8	0.3	4.3	0.81	101.9	92.6116	69.8194
2015	7	11	13	34	8	0.3	4.3	0.81	102.2	92.5459	69.4798
2015	7	11	13	44	8	0.3	4.3	0.85	101	92.4803	72.8858
2015	7	11	13	54	8	0.3	4.3	0.81	96.3	92.4803	70.8692
2015	7	11	14	4	8	0.3	4.3	0.8	98.9	92.4803	69.7169
2015	7	11	14	14	8	0.3	4.3	0.81	97	92.4803	70.8692
2015	7	11	14	24	8	0.3	4.3	0.8	101.1	92.5459	68.9032
2015	7	11	14	34	8	0.3	4.3	0.77	98.8	92.4803	66.836
2015	7	11	14	44	8	0.3	4.3	0.77	99.5	92.4147	66.7868
2015	7	11	14	54	8	0.3	4.3	0.77	100.7	92.4803	66.836
2015	7	11	15	4	8	0.3	4.3	0.78	98.4	92.4803	67.9884
2015	7	11	15	14	8	0.3	4.3	0.83	101.9	92.3491	71.0527
2015	7	11	15	24	8	0.3	4.3	0.82	97.8	92.3491	71.3404
2015	7	11	15	34	8	0.3	4.3	0.81	100.2	92.3491	70.1897
2015	7	11	15	44	8	0.3	4.3	0.78	97.7	92.2835	68.1259
2015	7	11	15	54	8	0.3	4.3	0.77	97.8	92.2835	67.2635
2015	7	11	16	4	8	0.3	4.3	0.79	97.9	92.3491	68.1761
2015	7	11	16	14	8	0.3	4.3	0.79	99.1	92.2835	68.1259
2015	7	11	16	24	8	0.3	4.3	0.77	97.9	92.2835	66.6887
2015	7	11	16	34	8	0.3	4.3	0.79	100.5	92.2835	68.1259
2015	7	11	16	44	8	0.3	4.3	0.82	96	92.2835	71.2879
2015	7	11	16	54	8	0.3	4.3	0.77	97.9	92.2835	66.6886
2015	7	11	17	4	8	0.3	4.3	0.8	99.9	92.2835	69.2757
2015	7	11	17	14	8	0.3	4.3	0.78	98.2	92.2179	67.7885
2015	7	11	17	24	8	0.3	4.3	0.77	98.3	92.2179	66.9268
2015	7	11	17	34	8	0.3	4.3	0.81	98.2	92.2179	70.0864
2015	7	11	17	44	8	0.3	4.3	0.8	100.4	92.2179	68.6502
2015	7	11	17	54	8	0.3	4.3	0.79	97.4	92.1522	68.3125
2015	7	11	18	4	8	0.3	4.3	0.79	98.4	92.2179	68.0757
2015	7	11	18	14	8	0.3	4.3	0.81	101.2	92.1522	69.7477
2015	7	11	18	24	8	0.3	4.3	0.78	98.4	92.1522	67.7385

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	11	18	34	8	0.3	4.3	0.83	98.6	92.1522	72.0439
2015	7	11	18	44	8	0.3	4.3	0.81	98.9	92.1522	69.7477
2015	7	11	18	54	8	0.3	4.3	0.79	99.8	92.1522	68.0255
2015	7	11	19	4	8	0.3	4.3	0.8	99.2	92.1522	69.1736
2015	7	11	19	14	8	0.3	4.3	0.78	95.8	92.1522	68.3125
2015	7	11	19	24	8	0.3	4.3	0.75	95.5	92.1522	65.4422
2015	7	11	19	34	8	0.3	4.3	0.8	96.6	92.0866	69.4093
2015	7	11	19	44	8	0.3	4.3	0.76	98.4	92.0866	65.9675
2015	7	11	19	54	8	0.3	4.3	0.84	97.8	92.0866	72.8511
2015	7	11	20	4	8	0.3	4.3	0.78	95.3	92.0866	68.262
2015	7	11	20	14	8	0.3	4.3	0.82	97.6	92.0866	71.1302
2015	7	11	20	24	8	0.3	4.3	0.74	95.6	92.0866	64.2466
2015	7	11	20	34	8	0.3	4.3	0.79	99.3	92.0866	68.262
2015	7	11	20	44	8	0.3	4.3	0.81	97.7	92.0866	70.2697
2015	7	11	20	54	8	0.3	4.3	0.77	97.6	92.0866	66.5411
2015	7	11	21	4	8	0.3	4.3	0.8	97.1	92.0866	69.4093
2015	7	11	21	14	8	0.3	4.3	0.78	97.7	92.0866	67.9752
2015	7	11	21	24	8	0.3	4.3	0.78	96.3	92.0866	67.9752
2015	7	11	21	34	8	0.3	4.3	0.77	96.2	92.0866	66.5411
2015	7	11	21	44	8	0.3	4.3	0.82	97.1	92.0866	71.1301
2015	7	11	21	54	8	0.3	4.3	0.82	96.9	92.0866	71.4169
2015	7	11	22	4	8	0.3	4.3	0.8	95.4	92.0866	69.4092
2015	7	11	22	14	8	0.3	4.3	0.82	97.8	92.0866	70.8433
2015	7	11	22	24	8	0.3	4.3	0.8	96.8	92.0866	69.4092
2015	7	11	22	34	8	0.3	4.3	0.79	97.6	92.0866	68.5488
2015	7	11	22	44	8	0.3	4.3	0.77	95.4	92.0866	67.1147
2015	7	11	22	54	8	0.3	4.3	0.8	97.6	92.0866	69.1224
2015	7	11	23	4	8	0.3	4.3	0.8	98	92.0866	69.1224
2015	7	11	23	14	8	0.3	4.3	0.8	95.2	92.0866	69.696
2015	7	11	23	24	8	0.3	4.3	0.8	95	92.0866	69.4092
2015	7	11	23	34	8	0.3	4.3	0.81	96.1	92.0866	70.2696
2015	7	11	23	44	8	0.3	4.3	0.79	96.9	92.0866	68.8356
2015	7	11	23	54	8	0.3	4.3	0.8	94.5	92.0866	69.696
2015	7	12	0	4	8	0.3	4.3	0.79	96.2	92.0866	68.8356
2015	7	12	0	14	8	0.3	4.3	0.8	96.8	92.0866	69.696
2015	7	12	0	24	8	0.3	4.3	0.81	96.3	92.0866	69.9829
2015	7	12	0	34	8	0.3	4.3	0.81	97	92.0866	69.9829
2015	7	12	0	44	8	0.3	4.3	0.78	95.5	92.0866	67.9752
2015	7	12	0	54	8	0.3	4.3	0.8	98	92.0866	69.4092
2015	7	12	1	4	8	0.3	4.3	0.76	95.2	92.0866	65.9675
2015	7	12	1	14	8	0.3	4.3	0.78	93.9	92.0866	67.9752
2015	7	12	1	24	8	0.3	4.3	0.75	95.5	92.0866	65.3939
2015	7	12	1	34	8	0.3	4.3	0.76	94.7	92.0866	66.5411
2015	7	12	1	44	8	0.3	4.3	0.8	97.3	92.0866	69.4093
2015	7	12	1	54	8	0.3	4.3	0.78	96.5	92.0866	67.9752
2015	7	12	2	4	8	0.3	4.3	0.82	97.6	92.0866	70.8434
2015	7	12	2	14	8	0.3	4.3	0.8	97.3	92.021	69.6447

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	12	2	24	8	0.3	4.3	0.78	95.5	92.0866	68.2621
2015	7	12	2	34	8	0.3	4.3	0.84	97.4	92.021	72.5107
2015	7	12	2	44	8	0.3	4.3	0.82	97.8	92.021	70.7911
2015	7	12	2	54	8	0.3	4.3	0.83	96.8	92.021	72.2241
2015	7	12	3	4	8	0.3	4.3	0.78	97.2	92.021	67.9251
2015	7	12	3	14	8	0.3	4.3	0.77	95.9	92.021	67.0653
2015	7	12	3	24	8	0.3	4.3	0.81	95.5	92.021	70.7911
2015	7	12	3	34	8	0.3	4.3	0.79	97.6	92.021	68.4983
2015	7	12	3	44	8	0.3	4.3	0.78	95.3	92.021	67.9251
2015	7	12	3	54	8	0.3	4.3	0.79	95.7	92.021	68.4984
2015	7	12	4	4	8	0.3	4.3	0.8	95.6	92.021	69.6448
2015	7	12	4	14	8	0.3	4.3	0.77	94.2	92.021	67.0654
2015	7	12	4	24	8	0.3	4.3	0.8	99.2	92.021	69.0716
2015	7	12	4	34	8	0.3	4.3	0.79	97.9	92.021	68.2118
2015	7	12	4	44	8	0.3	4.3	0.83	96.4	92.021	71.6511
2015	7	12	4	54	8	0.3	4.3	0.77	96.1	92.021	67.0654
2015	7	12	5	4	8	0.3	4.3	0.78	97	92.021	67.6386
2015	7	12	5	14	8	0.3	4.3	0.8	96.9	92.021	69.0717
2015	7	12	5	24	8	0.3	4.3	0.8	96.9	92.021	69.0717
2015	7	12	5	34	8	0.3	4.3	0.78	96.5	92.021	67.6387
2015	7	12	5	44	8	0.3	4.3	0.8	96.9	92.021	69.0717
2015	7	12	5	54	8	0.3	4.3	0.8	98.1	92.021	68.7851
2015	7	12	6	4	8	0.3	4.3	0.82	95.5	92.021	71.6512
2015	7	12	6	14	8	0.3	4.3	0.79	96.9	92.021	68.7851
2015	7	12	6	24	8	0.3	4.3	0.81	99.1	91.9554	69.8799
2015	7	12	6	34	8	0.3	4.3	0.79	95	91.9554	68.7343
2015	7	12	6	44	8	0.3	4.3	0.81	97.5	91.9554	69.8799
2015	7	12	6	54	8	0.3	4.3	0.79	96.2	91.9554	68.1616
2015	7	12	7	4	8	0.3	4.3	0.78	98	91.9554	67.3024
2015	7	12	7	14	8	0.3	4.3	0.82	97.4	91.9554	70.7391
2015	7	12	7	24	8	0.3	4.3	0.8	98.3	91.9554	68.7344
2015	7	12	7	34	8	0.3	4.3	0.81	93.5	91.9554	70.1664
2015	7	12	7	44	8	0.3	4.3	0.8	96.1	91.9554	69.5936
2015	7	12	7	54	8	0.3	4.3	0.79	96.9	91.9554	68.7344
2015	7	12	8	4	8	0.3	4.3	0.78	96.1	91.9554	67.3024
2015	7	12	8	14	8	0.3	4.3	0.81	97.7	91.9554	70.1663
2015	7	12	8	24	8	0.3	4.3	0.8	96.6	91.9554	69.0207
2015	7	12	8	34	8	0.3	4.3	0.81	97	91.9554	69.8799
2015	7	12	8	44	8	0.3	4.3	0.78	97.5	91.9554	67.3024
2015	7	12	8	54	8	0.3	4.3	0.78	96.3	91.9554	67.3024
2015	7	12	9	4	8	0.3	4.3	0.77	95.2	91.9554	66.7296
2015	7	12	9	14	8	0.3	4.3	0.8	95.9	91.9554	69.8799
2015	7	12	9	24	8	0.3	4.3	0.82	98	91.8898	71.2591
2015	7	12	9	34	8	0.3	4.3	0.8	99.7	91.8898	68.9696
2015	7	12	9	44	8	0.3	4.3	0.79	100.1	91.8898	67.5387
2015	7	12	9	54	8	0.3	4.3	0.82	100.9	91.8898	69.8281
2015	7	12	10	4	8	0.3	4.3	0.81	101.3	91.8898	68.9696

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	12	10	14	8	0.3	4.3	0.8	100.7	91.8898	68.3972
2015	7	12	10	24	8	0.3	4.3	0.82	100.4	91.8242	70.3484
2015	7	12	10	34	8	0.3	4.3	0.82	97.8	91.8242	70.9203
2015	7	12	10	44	8	0.3	4.3	0.82	97.8	91.8242	70.6343
2015	7	12	10	54	8	0.3	4.3	0.81	97.9	91.7585	69.7247
2015	7	12	11	4	8	0.3	4.3	0.8	99.2	91.7585	68.8674
2015	7	12	11	14	8	0.3	4.3	0.79	99.1	91.6929	67.9597
2015	7	12	11	24	8	0.3	4.3	0.81	101.4	91.6929	69.3874
2015	7	12	11	34	8	0.3	4.3	0.8	98.2	91.6929	69.1019
2015	7	12	11	44	8	0.3	4.3	0.79	103	91.6929	66.8175
2015	7	12	11	54	8	0.3	4.3	0.78	100.2	91.6273	66.7679
2015	7	12	12	4	8	0.3	4.3	0.82	99.7	91.6273	70.1919
2015	7	12	12	14	8	0.3	4.3	0.78	97.7	91.5617	67.2886
2015	7	12	12	24	8	0.3	4.3	0.79	100.3	91.5617	67.5737
2015	7	12	12	34	8	0.3	4.3	0.76	103.7	91.6273	64.4852
2015	7	12	12	44	8	0.3	4.3	0.8	100	91.5617	68.1439
2015	7	12	12	54	8	0.3	4.3	0.78	102.2	91.5617	66.148
2015	7	12	13	4	8	0.3	4.3	0.81	100	91.4961	69.2329
2015	7	12	13	14	8	0.3	4.3	0.81	101.4	91.4961	68.948
2015	7	12	13	24	8	0.3	4.3	0.8	100.4	91.5617	68.1439
2015	7	12	13	34	8	0.3	4.3	0.78	100.7	91.5617	66.4331
2015	7	12	13	44	8	0.3	4.3	0.81	101	91.4961	68.9479
2015	7	12	13	54	8	0.3	4.3	0.82	103.1	91.4961	69.5178
2015	7	12	14	4	8	0.3	4.3	0.78	99.2	91.4961	66.9536
2015	7	12	14	14	8	0.3	4.3	0.79	101	91.4305	67.4732
2015	7	12	14	24	8	0.3	4.3	0.79	98.1	91.4961	68.0932
2015	7	12	14	34	8	0.3	4.3	0.8	104	91.4961	67.2385
2015	7	12	14	44	8	0.3	4.3	0.82	98.9	91.4305	70.6049
2015	7	12	14	54	8	0.3	4.3	0.77	100.1	91.4305	65.4803
2015	7	12	15	4	8	0.3	4.3	0.8	103.1	91.3648	67.423
2015	7	12	15	14	8	0.3	4.3	0.78	100	91.3648	66.2851
2015	7	12	15	24	8	0.3	4.3	0.79	101.7	91.4305	67.1885
2015	7	12	15	34	8	0.3	4.3	0.78	96	91.3648	67.1385
2015	7	12	15	44	8	0.3	4.3	0.76	99.7	91.4305	65.1956
2015	7	12	15	54	8	0.3	4.3	0.8	99.2	91.3648	68.2765
2015	7	12	16	4	8	0.3	4.3	0.77	100.3	91.2992	65.6672
2015	7	12	16	14	8	0.3	4.3	0.77	99.6	91.3648	65.7161
2015	7	12	16	24	8	0.3	4.3	0.76	99.7	91.2992	64.8144
2015	7	12	16	34	8	0.3	4.3	0.8	98.1	91.2992	68.2256
2015	7	12	16	44	8	0.3	4.3	0.8	99.2	91.2992	68.7942
2015	7	12	16	54	8	0.3	4.3	0.8	100.4	91.2336	67.8907
2015	7	12	17	4	8	0.3	4.3	0.8	98	91.2336	68.4589
2015	7	12	17	14	8	0.3	4.3	0.81	97.2	91.2336	69.5951
2015	7	12	17	24	8	0.3	4.3	0.8	96.1	91.2336	68.743
2015	7	12	17	34	8	0.3	4.3	0.78	97.5	91.168	67.2724
2015	7	12	17	44	8	0.3	4.3	0.8	95.6	91.2336	69.3111
2015	7	12	17	54	8	0.3	4.3	0.78	94.6	91.2336	67.3226

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	12	18	4	8	0.3	4.3	0.8	96.4	91.168	68.4078
2015	7	12	18	14	8	0.3	4.3	0.81	98.4	91.2336	69.027
2015	7	12	18	24	8	0.3	4.3	0.8	98	91.168	68.4078
2015	7	12	18	34	8	0.3	4.3	0.8	98.5	91.168	68.124
2015	7	12	18	44	8	0.3	4.3	0.81	95.8	91.168	69.8271
2015	7	12	18	54	8	0.3	4.3	0.75	95.8	91.1024	64.6695
2015	7	12	19	4	8	0.3	4.3	0.81	98	91.168	68.9755
2015	7	12	19	14	8	0.3	4.3	0.77	96.9	91.1024	66.0877
2015	7	12	19	24	8	0.3	4.3	0.77	97.8	91.168	66.137
2015	7	12	19	34	8	0.3	4.3	0.82	96.9	91.168	70.3947
2015	7	12	19	44	8	0.3	4.3	0.79	98.4	91.168	67.5562
2015	7	12	19	54	8	0.3	4.3	0.78	96	91.168	66.9885
2015	7	12	20	4	8	0.3	4.3	0.77	96.4	91.168	66.137
2015	7	12	20	14	8	0.3	4.3	0.79	95.7	91.168	67.84
2015	7	12	20	24	8	0.3	4.3	0.8	97	91.168	68.9754
2015	7	12	20	34	8	0.3	4.3	0.8	98.5	91.1024	68.073
2015	7	12	20	44	8	0.3	4.3	0.79	95	91.1024	68.073
2015	7	12	20	54	8	0.3	4.3	0.81	98	91.1024	68.9239
2015	7	12	21	4	8	0.3	4.3	0.78	97.3	91.1024	66.6548
2015	7	12	21	14	8	0.3	4.3	0.8	96.6	91.1024	68.6403
2015	7	12	21	24	8	0.3	4.3	0.77	95.4	91.1024	66.3712
2015	7	12	21	34	8	0.3	4.3	0.82	100.1	91.168	69.8269
2015	7	12	21	44	8	0.3	4.3	0.8	96.4	91.168	68.4076
2015	7	12	21	54	8	0.3	4.3	0.81	99.6	91.168	68.6915
2015	7	12	22	4	8	0.3	4.3	0.76	97.5	91.1024	64.9529
2015	7	12	22	14	8	0.3	4.3	0.76	99.4	91.1024	65.2366
2015	7	12	22	24	8	0.3	4.3	0.8	97.6	91.168	68.4076
2015	7	12	22	34	8	0.3	4.3	0.76	96.7	91.168	65.5691
2015	7	12	22	44	8	0.3	4.3	0.78	94.8	91.168	67.2722
2015	7	12	22	54	8	0.3	4.3	0.76	95.2	91.168	65.2852
2015	7	12	23	4	8	0.3	4.3	0.81	97.2	91.168	69.2591
2015	7	12	23	14	8	0.3	4.3	0.8	96.8	91.168	68.6914
2015	7	12	23	24	8	0.3	4.3	0.82	96.5	91.168	70.1107
2015	7	12	23	34	8	0.3	4.3	0.81	97.2	91.168	69.543
2015	7	12	23	44	8	0.3	4.3	0.8	96.1	91.168	68.6914
2015	7	12	23	54	8	0.3	4.3	0.76	96.2	91.168	65.0014
2015	7	13	0	4	8	0.3	4.3	0.81	96.5	91.2336	69.3108
2015	7	13	0	14	8	0.3	4.3	0.81	95.6	91.2336	69.5948
2015	7	13	0	24	8	0.3	4.3	0.79	98.1	91.2336	67.6064
2015	7	13	0	34	8	0.3	4.3	0.79	95.2	91.168	68.4076
2015	7	13	0	44	8	0.3	4.3	0.74	94	91.2336	64.1977
2015	7	13	0	54	8	0.3	4.3	0.82	96.5	91.2336	70.163
2015	7	13	1	4	8	0.3	4.3	0.74	94.8	91.2336	64.1977
2015	7	13	1	14	8	0.3	4.3	0.79	96.2	91.2336	68.1746
2015	7	13	1	24	8	0.3	4.3	0.76	95.7	91.2336	65.9021
2015	7	13	1	34	8	0.3	4.3	0.79	97.1	91.2336	68.1746
2015	7	13	1	44	8	0.3	4.3	0.8	95.7	91.2336	68.7427

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	13	1	54	8	0.3	4.3	0.77	95.1	91.2336	66.4702
2015	7	13	2	4	8	0.3	4.3	0.78	97.3	91.2992	66.8041
2015	7	13	2	14	8	0.3	4.3	0.79	97.9	91.2992	67.3726
2015	7	13	2	24	8	0.3	4.3	0.79	96.7	91.2992	67.6569
2015	7	13	2	34	8	0.3	4.3	0.77	96.4	91.2992	65.9513
2015	7	13	2	44	8	0.3	4.3	0.78	92.9	91.2992	67.6569
2015	7	13	2	54	8	0.3	4.3	0.79	96.7	91.2992	68.2255
2015	7	13	3	4	8	0.3	4.3	0.78	94.1	91.2992	67.0884
2015	7	13	3	14	8	0.3	4.3	0.76	95.4	91.2992	65.6671
2015	7	13	3	24	8	0.3	4.3	0.77	95.9	91.2992	66.5199
2015	7	13	3	34	8	0.3	4.3	0.77	95.1	91.2992	66.8042
2015	7	13	3	44	8	0.3	4.3	0.79	94.7	91.2992	68.5098
2015	7	13	3	54	8	0.3	4.3	0.79	96.7	91.2992	67.657
2015	7	13	4	4	8	0.3	4.3	0.78	96.5	91.2992	67.3728
2015	7	13	4	14	8	0.3	4.3	0.78	97	91.2992	67.3728
2015	7	13	4	24	8	0.3	4.3	0.79	96.9	91.2992	67.6571
2015	7	13	4	34	8	0.3	4.3	0.75	95.8	91.2992	64.8144
2015	7	13	4	44	8	0.3	4.3	0.82	97.6	91.2992	70.2156
2015	7	13	4	54	8	0.3	4.3	0.79	96	91.2992	67.9414
2015	7	13	5	4	8	0.3	4.3	0.79	96.9	91.2992	67.6571
2015	7	13	5	14	8	0.3	4.3	0.8	97.3	91.2992	69.0785
2015	7	13	5	24	8	0.3	4.3	0.74	94.8	91.2992	64.2459
2015	7	13	5	34	8	0.3	4.3	0.79	97.4	91.2992	68.2257
2015	7	13	5	44	8	0.3	4.3	0.8	96.4	91.2992	68.7943
2015	7	13	5	54	8	0.3	4.3	0.8	95.7	91.2992	68.7943
2015	7	13	6	4	8	0.3	4.3	0.76	96.2	91.2992	65.383
2015	7	13	6	14	8	0.3	4.3	0.77	98.4	91.2992	65.6673
2015	7	13	6	24	8	0.3	4.3	0.74	99.4	91.2992	63.6774
2015	7	13	6	34	8	0.3	4.3	0.81	96.3	91.2992	69.3629
2015	7	13	6	44	8	0.3	4.3	0.78	96.3	91.2992	67.3729
2015	7	13	6	54	8	0.3	4.3	0.76	97.2	91.2992	65.383
2015	7	13	7	4	8	0.3	4.3	0.79	96.7	91.2992	67.6572
2015	7	13	7	14	8	0.3	4.3	0.78	97	91.2992	67.3729
2015	7	13	7	24	8	0.3	4.3	0.79	98.1	91.2992	67.6572
2015	7	13	7	34	8	0.3	4.3	0.79	97.4	91.2992	68.2258
2015	7	13	7	44	8	0.3	4.3	0.78	96.5	91.2992	67.3729
2015	7	13	7	54	8	0.3	4.3	0.79	98.8	91.2992	67.9415
2015	7	13	8	4	8	0.3	4.3	0.8	96.8	91.2992	68.7943
2015	7	13	8	14	8	0.3	4.3	0.79	96.4	91.2992	67.9415
2015	7	13	8	24	8	0.3	4.3	0.77	94.9	91.2992	66.2358
2015	7	13	8	34	8	0.3	4.3	0.79	97.2	91.2992	67.9414
2015	7	13	8	44	8	0.3	4.3	0.8	96.8	91.2992	68.7943
2015	7	13	8	54	8	0.3	4.3	0.75	95.8	91.2992	64.5302
2015	7	13	9	4	8	0.3	4.3	0.8	98.5	91.2992	68.7942
2015	7	13	9	14	8	0.3	4.3	0.79	97.2	91.2992	67.9414
2015	7	13	9	24	8	0.3	4.3	0.77	96.1	91.2992	66.52
2015	7	13	9	34	8	0.3	4.3	0.77	95.6	91.2992	66.2357

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	13	9	44	8	0.3	4.3	0.8	98.3	91.2992	68.5099
2015	7	13	9	54	8	0.3	4.3	0.78	96.3	91.2992	66.8042
2015	7	13	10	4	8	0.3	4.3	0.77	97.9	91.2336	65.6182
2015	7	13	10	14	8	0.3	4.3	0.81	97.9	91.2336	69.8791
2015	7	13	10	24	8	0.3	4.3	0.8	97.1	91.2336	68.4588
2015	7	13	10	34	8	0.3	4.3	0.82	97.5	91.2336	70.7312
2015	7	13	10	44	8	0.3	4.3	0.79	97.2	91.2336	67.8906
2015	7	13	10	54	8	0.3	4.3	0.81	97.9	91.2336	69.5949
2015	7	13	11	4	8	0.3	4.3	0.78	103.4	91.2336	65.6181
2015	7	13	11	14	8	0.3	4.3	0.78	96.3	91.2336	66.7544
2015	7	13	11	24	8	0.3	4.3	0.79	98.4	91.168	67.5562
2015	7	13	11	34	8	0.3	4.3	0.81	102.2	91.168	68.4077
2015	7	13	11	44	8	0.3	4.3	0.79	101.8	91.168	66.7045
2015	7	13	11	54	8	0.3	4.3	0.79	102.9	91.1024	66.9384
2015	7	13	12	4	8	0.3	4.3	0.79	103	91.1024	66.3711
2015	7	13	12	14	8	0.3	4.3	0.78	98.9	91.0368	66.8884
2015	7	13	12	24	8	0.3	4.3	0.79	96.7	91.0368	68.0221
2015	7	13	12	34	8	0.3	4.3	0.78	101.4	91.0368	66.3215
2015	7	13	12	44	8	0.3	4.3	0.79	102.7	90.9711	66.5551
2015	7	13	12	54	8	0.3	4.3	0.78	99.9	90.9711	66.2719
2015	7	13	13	4	8	0.3	4.3	0.77	99.8	90.9711	65.7055
2015	7	13	13	14	8	0.3	4.3	0.81	99.1	90.9055	68.7693
2015	7	13	13	24	8	0.3	4.3	0.79	99.6	90.9055	67.0713
2015	7	13	13	34	8	0.3	4.3	0.79	102.7	90.9055	66.5053
2015	7	13	13	44	8	0.3	4.3	0.76	97.7	90.9711	65.139
2015	7	13	13	54	8	0.3	4.3	0.77	101.3	90.9055	65.0903
2015	7	13	14	4	8	0.3	4.3	0.79	98.2	90.8399	67.0211
2015	7	13	14	14	8	0.3	4.3	0.81	99.8	90.8399	69.0006
2015	7	13	14	24	8	0.3	4.3	0.78	101.6	90.8399	66.1727
2015	7	13	14	34	8	0.3	4.3	0.79	98.1	90.9055	67.6373
2015	7	13	14	44	8	0.3	4.3	0.78	97	90.8399	66.7383
2015	7	13	14	54	8	0.3	4.3	0.8	101.4	90.8399	67.3039
2015	7	13	15	4	8	0.3	4.3	0.77	100.1	90.8399	65.0415
2015	7	13	15	14	8	0.3	4.3	0.77	100.1	90.7743	64.9929
2015	7	13	15	24	8	0.3	4.3	0.77	103	90.8399	64.7588
2015	7	13	15	34	8	0.3	4.3	0.77	101.3	90.7743	64.9929
2015	7	13	15	44	8	0.3	4.3	0.75	98.8	90.8399	63.9104
2015	7	13	15	54	8	0.3	4.3	0.81	95.8	90.8399	69.5662
2015	7	13	16	4	8	0.3	4.3	0.78	99.7	90.7743	65.8406
2015	7	13	16	14	8	0.3	4.3	0.8	97.1	90.7743	68.1012
2015	7	13	16	24	8	0.3	4.3	0.8	99	90.7743	67.8187
2015	7	13	16	34	8	0.3	4.3	0.8	99.5	90.8399	67.8695
2015	7	13	16	44	8	0.3	4.3	0.77	98.5	90.8399	65.89
2015	7	13	16	54	8	0.3	4.3	0.77	97.8	90.7743	65.8406
2015	7	13	17	4	8	0.3	4.3	0.76	96	90.7743	64.7103
2015	7	13	17	14	8	0.3	4.3	0.8	99.7	90.7743	67.5361
2015	7	13	17	24	8	0.3	4.3	0.76	98.9	90.7087	64.9442

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	13	17	34	8	0.3	4.3	0.79	99.3	90.7087	67.4855
2015	7	13	17	44	8	0.3	4.3	0.77	97.8	90.7087	65.7913
2015	7	13	17	54	8	0.3	4.3	0.81	96.1	90.7087	68.8973
2015	7	13	18	4	8	0.3	4.3	0.79	98.6	90.7087	66.9207
2015	7	13	18	14	8	0.3	4.3	0.8	100.4	90.7087	67.4855
2015	7	13	18	24	8	0.3	4.3	0.76	98.9	90.7087	64.9442
2015	7	13	18	34	8	0.3	4.3	0.8	99.5	90.7087	67.7678
2015	7	13	18	44	8	0.3	4.3	0.81	98.8	90.7087	69.1796
2015	7	13	18	54	8	0.3	4.3	0.8	97.5	90.5774	68.512
2015	7	13	19	4	8	0.3	4.3	0.78	96.3	90.6431	66.8705
2015	7	13	19	14	8	0.3	4.3	0.8	98	90.7087	68.3325
2015	7	13	19	24	8	0.3	4.3	0.79	98.3	90.7087	67.4854
2015	7	13	19	34	8	0.3	4.3	0.81	100.2	90.7087	68.8972
2015	7	13	19	44	8	0.3	4.3	0.81	97.7	90.7087	68.8972
2015	7	13	19	54	8	0.3	4.3	0.77	96.2	90.7087	65.5088
2015	7	13	20	4	8	0.3	4.3	0.77	95.9	90.7087	65.7912
2015	7	13	20	14	8	0.3	4.3	0.79	95.5	90.7087	67.7677
2015	7	13	20	24	8	0.3	4.3	0.77	98.5	90.7087	65.7912
2015	7	13	20	34	8	0.3	4.3	0.79	97.6	90.7087	67.4853
2015	7	13	20	44	8	0.3	4.3	0.79	96.5	90.7087	67.203
2015	7	13	20	54	8	0.3	4.3	0.77	98.1	90.7087	65.5088
2015	7	13	21	4	8	0.3	4.3	0.81	97.9	90.7087	68.8971
2015	7	13	21	14	8	0.3	4.3	0.77	97.6	90.7743	65.5579
2015	7	13	21	24	8	0.3	4.3	0.8	96.6	90.7743	68.3836
2015	7	13	21	34	8	0.3	4.3	0.77	97.5	90.7743	66.123
2015	7	13	21	44	8	0.3	4.3	0.81	97.9	90.7743	68.9488
2015	7	13	21	54	8	0.3	4.3	0.8	97.1	90.7743	68.101
2015	7	13	22	4	8	0.3	4.3	0.8	97.3	90.7743	68.3836
2015	7	13	22	14	8	0.3	4.3	0.77	95.4	90.7743	65.8404
2015	7	13	22	24	8	0.3	4.3	0.76	97.9	90.7743	64.9927
2015	7	13	22	34	8	0.3	4.3	0.78	95.8	90.7743	66.4055
2015	7	13	22	44	8	0.3	4.3	0.81	99.8	90.7743	68.6662
2015	7	13	22	54	8	0.3	4.3	0.78	96.8	90.7743	66.4055
2015	7	13	23	4	8	0.3	4.3	0.78	95.5	90.7743	66.9707
2015	7	13	23	14	8	0.3	4.3	0.77	95.4	90.7743	65.8404
2015	7	13	23	24	8	0.3	4.3	0.78	97.3	90.7743	66.4055
2015	7	13	23	34	8	0.3	4.3	0.77	96.3	90.7743	66.1229
2015	7	13	23	44	8	0.3	4.3	0.76	97.2	90.7743	65.2752
2015	7	13	23	54	8	0.3	4.3	0.76	97.4	90.7743	65.2752
2015	7	14	0	4	8	0.3	4.3	0.78	98.7	90.7743	66.4055
2015	7	14	0	14	8	0.3	4.3	0.76	96.7	90.7743	65.2752
2015	7	14	0	24	8	0.3	4.3	0.81	96.8	90.7743	69.2313
2015	7	14	0	34	8	0.3	4.3	0.76	96.2	90.8399	64.7586
2015	7	14	0	44	8	0.3	4.3	0.79	98.1	90.8399	67.3037
2015	7	14	0	54	8	0.3	4.3	0.76	97.2	90.7743	65.2752
2015	7	14	1	4	8	0.3	4.3	0.78	95.8	90.7743	66.9707
2015	7	14	1	14	8	0.3	4.3	0.77	97.5	90.8399	66.1725

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	14	1	24	8	0.3	4.3	0.8	98.1	90.8399	67.8693
2015	7	14	1	34	8	0.3	4.3	0.76	97.5	90.8399	64.7586
2015	7	14	1	44	8	0.3	4.3	0.79	96.4	90.8399	67.8693
2015	7	14	1	54	8	0.3	4.3	0.78	95.5	90.8399	67.0209
2015	7	14	2	4	8	0.3	4.3	0.81	96.8	90.8399	69.2833
2015	7	14	2	14	8	0.3	4.3	0.74	95.8	90.8399	63.6275
2015	7	14	2	24	8	0.3	4.3	0.78	96.8	90.8399	66.4554
2015	7	14	2	34	8	0.3	4.3	0.78	99.7	90.8399	66.4554
2015	7	14	2	44	8	0.3	4.3	0.8	96.9	90.8399	68.1521
2015	7	14	2	54	8	0.3	4.3	0.76	97	90.8399	64.7587
2015	7	14	3	4	8	0.3	4.3	0.79	97.2	90.8399	67.3038
2015	7	14	3	14	8	0.3	4.3	0.79	96.7	90.9055	67.6372
2015	7	14	3	24	8	0.3	4.3	0.76	95.7	90.9055	65.6562
2015	7	14	3	34	8	0.3	4.3	0.79	94.5	90.9055	67.9202
2015	7	14	3	44	8	0.3	4.3	0.74	95.9	90.9055	63.3922
2015	7	14	3	54	8	0.3	4.3	0.8	96.1	90.9055	68.4863
2015	7	14	4	4	8	0.3	4.3	0.77	96.1	90.9055	66.2223
2015	7	14	4	14	8	0.3	4.3	0.8	95.4	90.9055	68.4863
2015	7	14	4	24	8	0.3	4.3	0.73	97	90.9055	62.5433
2015	7	14	4	34	8	0.3	4.3	0.78	98.2	90.9055	66.5053
2015	7	14	4	44	8	0.3	4.3	0.81	96	90.9711	69.9536
2015	7	14	4	54	8	0.3	4.3	0.78	95.1	90.9055	67.0713
2015	7	14	5	4	8	0.3	4.3	0.77	96.2	90.9711	65.7055
2015	7	14	5	14	8	0.3	4.3	0.79	97.2	90.9711	67.4048
2015	7	14	5	24	8	0.3	4.3	0.77	96.1	90.9711	66.2719
2015	7	14	5	34	8	0.3	4.3	0.79	95.7	90.9711	67.688
2015	7	14	5	44	8	0.3	4.3	0.81	96.3	90.9711	69.1041
2015	7	14	5	54	8	0.3	4.3	0.79	97.1	91.0368	68.0221
2015	7	14	6	4	8	0.3	4.3	0.76	96.2	91.1024	65.2365
2015	7	14	6	14	8	0.3	4.3	0.77	94.9	91.1024	66.6547
2015	7	14	6	24	8	0.3	4.3	0.79	95.5	91.1024	68.0729
2015	7	14	6	34	8	0.3	4.3	0.76	96	91.168	65.0014
2015	7	14	6	44	8	0.3	4.3	0.79	95	91.168	67.8399
2015	7	14	6	54	8	0.3	4.3	0.76	97.2	91.168	65.5691
2015	7	14	7	4	8	0.3	4.3	0.73	97.2	91.168	63.0145
2015	7	14	7	14	8	0.3	4.3	0.79	96	91.168	67.8399
2015	7	14	7	24	8	0.3	4.3	0.8	96.8	91.168	68.9753
2015	7	14	7	34	8	0.3	4.3	0.77	96.9	91.168	65.853
2015	7	14	7	44	8	0.3	4.3	0.79	97.2	91.168	67.5561
2015	7	14	7	54	8	0.3	4.3	0.77	95.9	91.168	66.1368
2015	7	14	8	4	8	0.3	4.3	0.78	98.2	91.168	66.9884
2015	7	14	8	14	8	0.3	4.3	0.78	96.8	91.168	66.7045
2015	7	14	8	24	8	0.3	4.3	0.78	98.5	91.168	66.4207
2015	7	14	8	34	8	0.3	4.3	0.77	98.3	91.168	66.1368
2015	7	14	8	44	8	0.3	4.3	0.78	96.3	91.168	67.2722
2015	7	14	8	54	8	0.3	4.3	0.77	96.8	91.168	66.4206
2015	7	14	9	4	8	0.3	4.3	0.77	97.3	91.168	66.4206

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	14	9	14	8	0.3	4.3	0.78	99.2	91.1024	66.3711
2015	7	14	9	24	8	0.3	4.3	0.79	99.6	91.1024	66.9383
2015	7	14	9	34	8	0.3	4.3	0.81	98.8	91.0368	69.4392
2015	7	14	9	44	8	0.3	4.3	0.8	99.5	90.9711	67.688
2015	7	14	9	54	8	0.3	4.3	0.8	98	90.9711	68.5376
2015	7	14	10	4	8	0.3	4.3	0.8	100.7	90.9711	67.688
2015	7	14	10	14	8	0.3	4.3	0.77	102.1	90.9055	64.5243
2015	7	14	10	24	8	0.3	4.3	0.79	102.4	90.9055	66.7883
2015	7	14	10	34	8	0.3	4.3	0.79	99.8	90.9055	67.0713
2015	7	14	10	44	8	0.3	4.3	0.79	99.1	90.9055	67.0713
2015	7	14	10	54	8	0.3	4.3	0.78	98.3	90.9055	66.2223
2015	7	14	11	4	8	0.3	4.3	0.74	103.1	90.9055	62.2602
2015	7	14	11	14	8	0.3	4.3	0.78	100.6	90.9055	66.5052
2015	7	14	11	24	8	0.3	4.3	0.79	98.3	90.9055	67.6372
2015	7	14	11	34	8	0.3	4.3	0.77	102.8	90.9055	64.8072
2015	7	14	11	44	8	0.3	4.3	0.81	103.6	90.9055	67.9202
2015	7	14	11	54	8	0.3	4.3	0.79	101.8	90.9055	66.5052
2015	7	14	12	4	8	0.3	4.3	0.81	97.9	90.9055	69.3352
2015	7	14	12	14	8	0.3	4.3	0.79	99.6	90.9055	67.0711
2015	7	14	12	24	8	0.3	4.3	0.78	101.6	90.8399	66.1726
2015	7	14	12	34	8	0.3	4.3	0.78	102.1	90.9055	65.9391
2015	7	14	12	44	8	0.3	4.3	0.78	103.2	90.8399	65.3242
2015	7	14	12	54	8	0.3	4.3	0.76	103.7	90.8399	63.6275
2015	7	14	13	4	8	0.3	4.3	0.8	101.6	90.9055	67.3541
2015	7	14	13	14	8	0.3	4.3	0.78	97.3	90.8399	66.4553
2015	7	14	13	24	8	0.3	4.3	0.79	102.8	90.7743	66.123
2015	7	14	13	34	8	0.3	4.3	0.77	99.3	90.8399	65.6069
2015	7	14	13	44	8	0.3	4.3	0.76	98.7	90.7743	64.7101
2015	7	14	13	54	8	0.3	4.3	0.78	97.7	90.8399	66.7381
2015	7	14	14	4	8	0.3	4.3	0.8	96.8	90.7743	68.3836
2015	7	14	14	14	8	0.3	4.3	0.77	101.1	90.7743	64.9926
2015	7	14	14	24	8	0.3	4.3	0.78	96	90.7743	66.6881
2015	7	14	14	34	8	0.3	4.3	0.79	97.1	90.7743	67.8184
2015	7	14	14	44	8	0.3	4.3	0.79	95.7	90.7743	67.5358
2015	7	14	14	54	8	0.3	4.3	0.81	101.7	90.7743	68.101
2015	7	14	15	4	8	0.3	4.3	0.8	100.7	90.7087	67.4852
2015	7	14	15	14	8	0.3	4.3	0.77	102.1	90.7087	64.3792
2015	7	14	15	24	8	0.3	4.3	0.79	97.9	90.7743	66.9707
2015	7	14	15	34	8	0.3	4.3	0.77	97.5	90.7087	66.0734
2015	7	14	15	44	8	0.3	4.3	0.76	99.7	90.6431	64.3309
2015	7	14	15	54	8	0.3	4.3	0.78	99.2	90.7087	66.3557
2015	7	14	16	4	8	0.3	4.3	0.76	101.9	90.6431	64.0488
2015	7	14	16	14	8	0.3	4.3	0.75	96.6	90.6431	63.7666
2015	7	14	16	24	8	0.3	4.3	0.77	98.6	90.6431	65.1774
2015	7	14	16	34	8	0.3	4.3	0.81	97.4	90.6431	69.4097
2015	7	14	16	44	8	0.3	4.3	0.7	107.9	90.6431	57.5592
2015	7	14	16	54	8	0.3	4.3	0.75	101.9	90.6431	62.9201

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	14	17	4	8	0.3	4.3	0.79	97.6	90.6431	67.7167
2015	7	14	17	14	8	0.3	4.3	0.79	100.1	90.6431	66.5881
2015	7	14	17	24	8	0.3	4.3	0.77	98.4	90.5774	65.1284
2015	7	14	17	34	8	0.3	4.3	0.75	98.6	90.6431	63.7666
2015	7	14	17	44	8	0.3	4.3	0.78	97.7	90.6431	66.5881
2015	7	14	17	54	8	0.3	4.3	0.75	100.1	90.5774	63.4368
2015	7	14	18	4	8	0.3	4.3	0.78	98.4	90.5774	66.5381
2015	7	14	18	14	8	0.3	4.3	0.79	101.4	90.5774	66.8201
2015	7	14	18	24	8	0.3	4.3	0.78	97.7	90.5774	66.5381
2015	7	14	18	34	8	0.3	4.3	0.8	99.2	90.6431	67.7167
2015	7	14	18	44	8	0.3	4.3	0.8	98.3	90.6431	67.9989
2015	7	14	18	54	8	0.3	4.3	0.78	101.9	90.6431	65.7416
2015	7	14	19	4	8	0.3	4.3	0.8	98.9	90.6431	68.281
2015	7	14	19	14	8	0.3	4.3	0.79	100	90.5774	67.102
2015	7	14	19	24	8	0.3	4.3	0.82	99.7	90.6431	69.4096
2015	7	14	19	34	8	0.3	4.3	0.77	96.1	90.6431	66.0237
2015	7	14	19	44	8	0.3	4.3	0.81	97.9	90.6431	69.4096
2015	7	14	19	54	8	0.3	4.3	0.78	97.5	90.6431	66.588
2015	7	14	20	4	8	0.3	4.3	0.76	95.4	90.6431	65.1773
2015	7	14	20	14	8	0.3	4.3	0.79	97.9	90.6431	67.4345
2015	7	14	20	24	8	0.3	4.3	0.8	100.2	90.6431	67.4344
2015	7	14	20	34	8	0.3	4.3	0.77	97.4	90.6431	65.4594
2015	7	14	20	44	8	0.3	4.3	0.79	96.9	90.6431	67.1523
2015	7	14	20	54	8	0.3	4.3	0.76	96.4	90.6431	65.1772
2015	7	14	21	4	8	0.3	4.3	0.75	97.1	90.6431	63.7664
2015	7	14	21	14	8	0.3	4.3	0.77	97.4	90.5774	65.4102
2015	7	14	21	24	8	0.3	4.3	0.78	97	90.6431	66.3058
2015	7	14	21	34	8	0.3	4.3	0.78	95.8	90.5774	66.256
2015	7	14	21	44	8	0.3	4.3	0.76	96.4	90.6431	65.1772
2015	7	14	21	54	8	0.3	4.3	0.81	96.5	90.6431	68.8451
2015	7	14	22	4	8	0.3	4.3	0.77	96.1	90.6431	66.0236
2015	7	14	22	14	8	0.3	4.3	0.75	97.5	90.7087	64.379
2015	7	14	22	24	8	0.3	4.3	0.78	98.5	90.7087	66.0731
2015	7	14	22	34	8	0.3	4.3	0.79	96	90.7087	67.2026
2015	7	14	22	44	8	0.3	4.3	0.78	97.3	90.7087	66.3555
2015	7	14	22	54	8	0.3	4.3	0.75	97.5	90.7087	64.0966
2015	7	14	23	4	8	0.3	4.3	0.78	97.2	90.7087	66.6378
2015	7	14	23	14	8	0.3	4.3	0.81	96.8	90.7087	68.8967
2015	7	14	23	24	8	0.3	4.3	0.77	97.4	90.7087	65.5084
2015	7	14	23	34	8	0.3	4.3	0.76	96.7	90.7087	64.9436
2015	7	14	23	44	8	0.3	4.3	0.78	96	90.7087	66.6378
2015	7	14	23	54	8	0.3	4.3	0.76	96.4	90.7087	65.226
2015	7	15	0	4	8	0.3	4.3	0.78	96.5	90.7087	66.6378
2015	7	15	0	14	8	0.3	4.3	0.82	93.9	90.7087	70.0262
2015	7	15	0	24	8	0.3	4.3	0.8	96.8	90.7087	68.332
2015	7	15	0	34	8	0.3	4.3	0.76	96.5	90.7087	64.6613
2015	7	15	0	44	8	0.3	4.3	0.79	96.9	90.7743	67.253

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	15	0	54	8	0.3	4.3	0.79	97.4	90.7743	67.5355
2015	7	15	1	4	8	0.3	4.3	0.74	94.1	90.7743	63.2969
2015	7	15	1	14	8	0.3	4.3	0.78	97	90.7743	66.4053
2015	7	15	1	24	8	0.3	4.3	0.74	95.1	90.7743	63.5795
2015	7	15	1	34	8	0.3	4.3	0.79	95	90.7743	68.1007
2015	7	15	1	44	8	0.3	4.3	0.79	94.8	90.7743	67.8182
2015	7	15	1	54	8	0.3	4.3	0.76	95.7	90.7743	64.7098
2015	7	15	2	4	8	0.3	4.3	0.77	97.3	90.7743	65.8402
2015	7	15	2	14	8	0.3	4.3	0.76	95	90.7743	64.9924
2015	7	15	2	24	8	0.3	4.3	0.75	94.8	90.7743	64.4273
2015	7	15	2	34	8	0.3	4.3	0.75	96	90.7743	64.4273
2015	7	15	2	44	8	0.3	4.3	0.79	96.2	90.7743	67.5357
2015	7	15	2	54	8	0.3	4.3	0.75	94.8	90.7743	64.4273
2015	7	15	3	4	8	0.3	4.3	0.77	96.1	90.7743	65.8402
2015	7	15	3	14	8	0.3	4.3	0.79	97.6	90.7743	67.8183
2015	7	15	3	24	8	0.3	4.3	0.78	95.1	90.7743	66.9706
2015	7	15	3	34	8	0.3	4.3	0.76	95.9	90.7743	65.2751
2015	7	15	3	44	8	0.3	4.3	0.78	95.8	90.7743	66.688
2015	7	15	3	54	8	0.3	4.3	0.78	93.9	90.7743	66.688
2015	7	15	4	4	8	0.3	4.3	0.75	95.8	90.7743	64.1449
2015	7	15	4	14	8	0.3	4.3	0.8	96.1	90.7743	68.3835
2015	7	15	4	24	8	0.3	4.3	0.74	95.3	90.7743	63.8623
2015	7	15	4	34	8	0.3	4.3	0.8	96.4	90.7743	68.101
2015	7	15	4	44	8	0.3	4.3	0.79	96	90.7743	67.2533
2015	7	15	4	54	8	0.3	4.3	0.8	96.8	90.7743	68.3836
2015	7	15	5	4	8	0.3	4.3	0.77	96.8	90.7743	66.123
2015	7	15	5	14	8	0.3	4.3	0.79	94.5	90.7743	67.8185
2015	7	15	5	24	8	0.3	4.3	0.78	98.7	90.7743	66.123
2015	7	15	5	34	8	0.3	4.3	0.8	97.1	90.7743	68.1011
2015	7	15	5	44	8	0.3	4.3	0.78	95.5	90.7743	66.9708
2015	7	15	5	54	8	0.3	4.3	0.77	94.9	90.7743	66.4056
2015	7	15	6	4	8	0.3	4.3	0.77	95.6	90.7743	66.4057
2015	7	15	6	14	8	0.3	4.3	0.78	97.2	90.7743	66.9708
2015	7	15	6	24	8	0.3	4.3	0.74	94.3	90.7743	63.8625
2015	7	15	6	34	8	0.3	4.3	0.79	94.5	90.7743	68.1012
2015	7	15	6	44	8	0.3	4.3	0.77	95.4	90.7743	65.8406
2015	7	15	6	54	8	0.3	4.3	0.77	94.9	90.7743	65.8406
2015	7	15	7	4	8	0.3	4.3	0.79	93.1	90.7743	67.5361
2015	7	15	7	14	8	0.3	4.3	0.77	97.3	90.7743	65.8406
2015	7	15	7	24	8	0.3	4.3	0.75	96.5	90.7743	64.1451
2015	7	15	7	34	8	0.3	4.3	0.76	98.2	90.7743	64.9929
2015	7	15	7	44	8	0.3	4.3	0.77	95.3	90.7743	66.4057
2015	7	15	7	54	8	0.3	4.3	0.79	97.2	90.7743	67.5361
2015	7	15	8	4	8	0.3	4.3	0.77	97.8	90.7743	66.1232
2015	7	15	8	14	8	0.3	4.3	0.76	96.2	90.7743	64.7103
2015	7	15	8	24	8	0.3	4.3	0.79	97.2	90.7743	67.536
2015	7	15	8	34	8	0.3	4.3	0.76	96.9	90.7087	64.9441

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	15	8	44	8	0.3	4.3	0.81	96.5	90.7743	69.2315
2015	7	15	8	54	8	0.3	4.3	0.77	97.3	90.7743	65.8405
2015	7	15	9	4	8	0.3	4.3	0.76	99.5	90.7087	64.097
2015	7	15	9	14	8	0.3	4.3	0.8	100.2	90.7087	67.4854
2015	7	15	9	24	8	0.3	4.3	0.78	98	90.7087	66.0735
2015	7	15	9	34	8	0.3	4.3	0.76	99.4	90.7087	64.9441
2015	7	15	9	44	8	0.3	4.3	0.76	97.4	90.7087	65.2264
2015	7	15	9	54	8	0.3	4.3	0.76	99.4	90.7087	64.944
2015	7	15	10	4	8	0.3	4.3	0.78	100.2	90.7087	65.7911
2015	7	15	10	14	8	0.3	4.3	0.78	100.7	90.7087	65.7911
2015	7	15	10	24	8	0.3	4.3	0.78	98.7	90.7087	66.0734
2015	7	15	10	34	8	0.3	4.3	0.79	99.3	90.7087	67.2029
2015	7	15	10	44	8	0.3	4.3	0.78	99.7	90.7087	66.0734
2015	7	15	10	54	8	0.3	4.3	0.75	97.5	90.7087	64.0968
2015	7	15	11	4	8	0.3	4.3	0.79	102	90.7087	66.6381
2015	7	15	11	14	8	0.3	4.3	0.77	101	90.7087	65.2263
2015	7	15	11	24	8	0.3	4.3	0.79	97.9	90.7087	67.4852
2015	7	15	11	34	8	0.3	4.3	0.76	97.9	90.7087	64.9439
2015	7	15	11	44	8	0.3	4.3	0.78	102.6	90.6431	65.7416
2015	7	15	11	54	8	0.3	4.3	0.79	102.3	90.6431	66.0238
2015	7	15	12	4	8	0.3	4.3	0.8	99.9	90.6431	67.7167
2015	7	15	12	14	8	0.3	4.3	0.76	100.4	90.6431	64.3308
2015	7	15	12	24	8	0.3	4.3	0.79	102.1	90.6431	66.0237
2015	7	15	12	34	8	0.3	4.3	0.78	100.9	90.6431	66.0237
2015	7	15	12	44	8	0.3	4.3	0.78	98.2	90.6431	66.3058
2015	7	15	12	54	8	0.3	4.3	0.79	99.6	90.6431	66.588
2015	7	15	13	4	8	0.3	4.3	0.76	98.7	90.5774	64.5644
2015	7	15	13	14	8	0.3	4.3	0.76	101.2	90.5774	64.0005
2015	7	15	13	24	8	0.3	4.3	0.77	99.8	90.5774	65.4102
2015	7	15	13	34	8	0.3	4.3	0.77	102.7	90.5118	64.7976
2015	7	15	13	44	8	0.3	4.3	0.75	103.6	90.5118	62.8255
2015	7	15	13	54	8	0.3	4.3	0.78	101.9	90.5774	65.6921
2015	7	15	14	4	8	0.3	4.3	0.77	100.8	90.5118	65.0793
2015	7	15	14	14	8	0.3	4.3	0.76	100.9	90.4462	64.1859
2015	7	15	14	24	8	0.3	4.3	0.77	102.7	90.5118	64.7976
2015	7	15	14	34	8	0.3	4.3	0.76	98.7	90.4462	64.4674
2015	7	15	14	44	8	0.3	4.3	0.79	96.5	90.3806	66.9506
2015	7	15	14	54	8	0.3	4.3	0.77	100.5	90.4462	65.0304
2015	7	15	15	4	8	0.3	4.3	0.77	102.4	90.4462	64.1859
2015	7	15	15	14	8	0.3	4.3	0.75	100.5	90.4462	63.6228
2015	7	15	15	24	8	0.3	4.3	0.72	100.7	90.3806	61.0432
2015	7	15	15	34	8	0.3	4.3	0.75	101.9	90.3806	62.7311
2015	7	15	15	44	8	0.3	4.3	0.8	99.4	90.315	67.7435
2015	7	15	15	54	8	0.3	4.3	0.75	101.8	90.315	63.246
2015	7	15	16	4	8	0.3	4.3	0.75	96.3	90.3806	63.8563
2015	7	15	16	14	8	0.3	4.3	0.78	98.4	90.315	66.3381
2015	7	15	16	24	8	0.3	4.3	0.77	98.6	90.315	64.9326

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	15	16	34	8	0.3	4.3	0.75	99.5	90.315	63.5272
2015	7	15	16	44	8	0.3	4.3	0.74	102	90.315	62.1217
2015	7	15	16	54	8	0.3	4.3	0.77	97.3	90.315	65.7759
2015	7	15	17	4	8	0.3	4.3	0.79	100.6	90.2494	66.2881
2015	7	15	17	14	8	0.3	4.3	0.77	99.3	90.2494	64.8837
2015	7	15	17	24	8	0.3	4.3	0.76	100	90.2494	63.7602
2015	7	15	17	34	8	0.3	4.3	0.77	99.1	90.2494	64.8837
2015	7	15	17	44	8	0.3	4.3	0.78	100.2	90.2494	65.4455
2015	7	15	17	54	8	0.3	4.3	0.78	101	90.2494	65.1646
2015	7	15	18	4	8	0.3	4.3	0.74	100.2	90.2494	62.6367
2015	7	15	18	14	8	0.3	4.3	0.8	99.7	90.1837	67.6415
2015	7	15	18	24	8	0.3	4.3	0.77	103.8	90.2494	64.0411
2015	7	15	18	34	8	0.3	4.3	0.79	98.6	90.1837	66.5188
2015	7	15	18	44	8	0.3	4.3	0.76	100	90.1837	63.7121
2015	7	15	18	54	8	0.3	4.3	0.79	100.1	90.1837	66.2382
2015	7	15	19	4	8	0.3	4.3	0.77	100.3	90.1837	64.5541
2015	7	15	19	14	8	0.3	4.3	0.77	99.8	90.1181	64.7859
2015	7	15	19	24	8	0.3	4.3	0.78	98.7	90.1837	66.2381
2015	7	15	19	34	8	0.3	4.3	0.8	99.4	90.1837	67.9221
2015	7	15	19	44	8	0.3	4.3	0.76	97.4	90.1837	64.8348
2015	7	15	19	54	8	0.3	4.3	0.8	100.6	90.1837	67.3608
2015	7	15	20	4	8	0.3	4.3	0.76	98.7	90.1181	63.9445
2015	7	15	20	14	8	0.3	4.3	0.78	96.1	90.1181	65.9077
2015	7	15	20	24	8	0.3	4.3	0.8	99.9	90.1181	67.5904
2015	7	15	20	34	8	0.3	4.3	0.77	99.1	90.1181	64.7858
2015	7	15	20	44	8	0.3	4.3	0.79	100.3	90.1837	66.2381
2015	7	15	20	54	8	0.3	4.3	0.8	96.2	90.1181	67.5904
2015	7	15	21	4	8	0.3	4.3	0.77	97.4	90.1181	65.0662
2015	7	15	21	14	8	0.3	4.3	0.76	96.7	90.1181	64.7858
2015	7	15	21	24	8	0.3	4.3	0.77	98.1	90.1181	65.0662
2015	7	15	21	34	8	0.3	4.3	0.8	98.3	90.1181	67.5903
2015	7	15	21	44	8	0.3	4.3	0.78	98.5	90.1837	65.6767
2015	7	15	21	54	8	0.3	4.3	0.75	96.8	90.1837	63.712
2015	7	15	22	4	8	0.3	4.3	0.76	95.7	90.1837	64.8347
2015	7	15	22	14	8	0.3	4.3	0.72	96.8	90.1837	61.4666
2015	7	15	22	24	8	0.3	4.3	0.75	98.8	90.1837	63.1506
2015	7	15	22	34	8	0.3	4.3	0.76	97.4	90.1837	64.554
2015	7	15	22	44	8	0.3	4.3	0.75	94.8	90.1837	63.9926
2015	7	15	22	54	8	0.3	4.3	0.76	97.4	90.1837	64.8346
2015	7	15	23	4	8	0.3	4.3	0.76	100	90.1837	63.712
2015	7	15	23	14	8	0.3	4.3	0.75	95	90.1837	64.2733
2015	7	15	23	24	8	0.3	4.3	0.76	95.5	90.1837	64.554
2015	7	15	23	34	8	0.3	4.3	0.77	98.6	90.1837	64.8346
2015	7	15	23	44	8	0.3	4.3	0.74	98.2	90.1837	62.3086
2015	7	15	23	54	8	0.3	4.3	0.73	99.3	90.1837	61.4666
2015	7	16	0	4	8	0.3	4.3	0.78	97.3	90.1837	65.9573
2015	7	16	0	14	8	0.3	4.3	0.8	95.4	90.1837	68.4833

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	16	0	24	8	0.3	4.3	0.77	96.8	90.1837	65.6766
2015	7	16	0	34	8	0.3	4.3	0.72	96.6	90.1837	60.9053
2015	7	16	0	44	8	0.3	4.3	0.8	95.9	90.2494	67.9732
2015	7	16	0	54	8	0.3	4.3	0.76	97.2	90.2494	64.6027
2015	7	16	1	4	8	0.3	4.3	0.77	98.3	90.1837	65.396
2015	7	16	1	14	8	0.3	4.3	0.73	97.2	90.2494	62.3556
2015	7	16	1	24	8	0.3	4.3	0.77	96.2	90.2494	65.1645
2015	7	16	1	34	8	0.3	4.3	0.76	98.5	90.2494	64.0409
2015	7	16	1	44	8	0.3	4.3	0.75	95.8	90.2494	63.4792
2015	7	16	1	54	8	0.3	4.3	0.76	96.5	90.2494	64.3218
2015	7	16	2	4	8	0.3	4.3	0.75	95.8	90.2494	63.4792
2015	7	16	2	14	8	0.3	4.3	0.75	97.3	90.2494	63.7601
2015	7	16	2	24	8	0.3	4.3	0.75	97.1	90.2494	63.4792
2015	7	16	2	34	8	0.3	4.3	0.75	96.8	90.2494	63.7601
2015	7	16	2	44	8	0.3	4.3	0.75	95.8	90.2494	63.7601
2015	7	16	2	54	8	0.3	4.3	0.78	98.5	90.2494	66.0072
2015	7	16	3	4	8	0.3	4.3	0.75	98.6	90.2494	63.4792
2015	7	16	3	14	8	0.3	4.3	0.78	99.2	90.2494	65.7263
2015	7	16	3	24	8	0.3	4.3	0.75	96	90.2494	63.7601
2015	7	16	3	34	8	0.3	4.3	0.76	97	90.315	64.3704
2015	7	16	3	44	8	0.3	4.3	0.75	98.3	90.315	63.5271
2015	7	16	3	54	8	0.3	4.3	0.72	94.4	90.315	61.8406
2015	7	16	4	4	8	0.3	4.3	0.71	99.5	90.315	60.154
2015	7	16	4	14	8	0.3	4.3	0.75	97	90.315	63.8083
2015	7	16	4	24	8	0.3	4.3	0.78	99.7	90.3806	65.5442
2015	7	16	4	34	8	0.3	4.3	0.79	97.7	90.4462	67.0011
2015	7	16	4	44	8	0.3	4.3	0.73	97.7	90.4462	62.4969
2015	7	16	4	54	8	0.3	4.3	0.76	97.4	90.4462	64.749
2015	7	16	5	4	8	0.3	4.3	0.77	97.8	90.5118	65.6429
2015	7	16	5	14	8	0.3	4.3	0.75	99.3	90.5118	63.6708
2015	7	16	5	24	8	0.3	4.3	0.78	97.2	90.5118	66.4881
2015	7	16	5	34	8	0.3	4.3	0.75	97.5	90.5118	63.9526
2015	7	16	5	44	8	0.3	4.3	0.77	96.1	90.5118	65.643
2015	7	16	5	54	8	0.3	4.3	0.77	96.2	90.5118	65.3612
2015	7	16	6	4	8	0.3	4.3	0.75	96.8	90.5118	63.6709
2015	7	16	6	14	8	0.3	4.3	0.74	98.5	90.5118	62.544
2015	7	16	6	24	8	0.3	4.3	0.75	98.6	90.5118	63.3892
2015	7	16	6	34	8	0.3	4.3	0.77	96.9	90.5118	65.3613
2015	7	16	6	44	8	0.3	4.3	0.76	95	90.5118	64.7978
2015	7	16	6	54	8	0.3	4.3	0.74	95.9	90.5118	63.1075
2015	7	16	7	4	8	0.3	4.3	0.76	97.5	90.5118	64.5161
2015	7	16	7	14	8	0.3	4.3	0.76	98.7	90.5118	64.2344
2015	7	16	7	24	8	0.3	4.3	0.76	99.4	90.5118	64.7979
2015	7	16	7	34	8	0.3	4.3	0.76	97.9	90.5118	64.7979
2015	7	16	7	44	8	0.3	4.3	0.74	99.9	90.5118	62.8258
2015	7	16	7	54	8	0.3	4.3	0.78	98.5	90.5118	66.2065
2015	7	16	8	4	8	0.3	4.3	0.77	98.6	90.5118	65.0796

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	16	8	14	8	0.3	4.3	0.79	98.4	90.5118	67.0517
2015	7	16	8	24	8	0.3	4.3	0.77	98.4	90.5118	65.0796
2015	7	16	8	34	8	0.3	4.3	0.77	97.8	90.5118	65.643
2015	7	16	8	44	8	0.3	4.3	0.78	97.3	90.5118	66.2065
2015	7	16	8	54	8	0.3	4.3	0.77	97.8	90.5118	65.643
2015	7	16	9	4	8	0.3	4.3	0.78	100.4	90.5118	65.9247
2015	7	16	9	14	8	0.3	4.3	0.78	102.2	90.5118	65.0795
2015	7	16	9	24	8	0.3	4.3	0.75	102.3	90.4462	63.06
2015	7	16	9	34	8	0.3	4.3	0.78	101	90.4462	65.3121
2015	7	16	9	44	8	0.3	4.3	0.76	100.2	90.3806	64.4191
2015	7	16	9	54	8	0.3	4.3	0.75	99.8	90.3806	63.5751
2015	7	16	10	4	8	0.3	4.3	0.77	101.1	90.315	64.6516
2015	7	16	10	14	8	0.3	4.3	0.79	99.5	90.315	66.9004
2015	7	16	10	24	8	0.3	4.3	0.76	102.2	90.2494	63.4794
2015	7	16	10	34	8	0.3	4.3	0.79	99.1	90.2494	66.5691
2015	7	16	10	44	8	0.3	4.3	0.75	100	90.2494	63.4794
2015	7	16	10	54	8	0.3	4.3	0.78	102.9	90.2494	65.1646
2015	7	16	11	4	8	0.3	4.3	0.76	103.1	90.1837	63.7122
2015	7	16	11	14	8	0.3	4.3	0.77	101.1	90.1837	64.5542
2015	7	16	11	24	8	0.3	4.3	0.75	101.8	90.2494	63.1984
2015	7	16	11	34	8	0.3	4.3	0.76	101	90.1837	63.4315
2015	7	16	11	44	8	0.3	4.3	0.78	100.9	90.1837	65.6768
2015	7	16	11	54	8	0.3	4.3	0.79	100.3	90.1837	66.5188
2015	7	16	12	4	8	0.3	4.3	0.75	100.1	90.1837	62.8701
2015	7	16	12	14	8	0.3	4.3	0.77	103.6	90.1837	63.7121
2015	7	16	12	24	8	0.3	4.3	0.78	102.2	90.1181	64.7858
2015	7	16	12	34	8	0.3	4.3	0.76	100.2	90.1181	64.2249
2015	7	16	12	44	8	0.3	4.3	0.78	101.6	90.1181	65.6272
2015	7	16	12	54	8	0.3	4.3	0.76	98.7	90.1181	63.9444
2015	7	16	13	4	8	0.3	4.3	0.75	103.7	90.1181	61.9812
2015	7	16	13	14	8	0.3	4.3	0.74	99	90.1181	62.2617
2015	7	16	13	24	8	0.3	4.3	0.77	101.5	90.1181	64.5053
2015	7	16	13	34	8	0.3	4.3	0.79	102.5	90.1181	65.9076
2015	7	16	13	44	8	0.3	4.3	0.75	101.9	90.1181	62.5421
2015	7	16	13	54	8	0.3	4.3	0.76	103.4	90.0525	63.3356
2015	7	16	14	4	8	0.3	4.3	0.76	104	90.0525	62.7751
2015	7	16	14	14	8	0.3	4.3	0.76	101.9	90.0525	63.6159
2015	7	16	14	24	8	0.3	4.3	0.76	103.5	90.0525	63.0554
2015	7	16	14	34	8	0.3	4.3	0.74	102.1	90.0525	61.6541
2015	7	16	14	44	8	0.3	4.3	0.77	102.1	90.0525	63.8961
2015	7	16	14	54	8	0.3	4.3	0.79	101.8	90.0525	65.8578
2015	7	16	15	4	8	0.3	4.3	0.78	100.9	90.0525	65.5775
2015	7	16	15	14	8	0.3	4.3	0.76	104.3	90.0525	62.4949
2015	7	16	15	24	8	0.3	4.3	0.75	99.3	90.0525	63.3356
2015	7	16	15	34	8	0.3	4.3	0.76	100.2	89.9869	64.1278
2015	7	16	15	44	8	0.3	4.3	0.74	101.8	89.9869	61.6075
2015	7	16	15	54	8	0.3	4.3	0.74	102.7	89.9869	61.8876

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	16	16	4	8	0.3	4.3	0.77	101.7	89.9869	64.688
2015	7	16	16	14	8	0.3	4.3	0.75	99	89.9869	63.5678
2015	7	16	16	24	8	0.3	4.3	0.78	101	89.9213	64.9189
2015	7	16	16	34	8	0.3	4.3	0.72	100.2	89.9869	60.4874
2015	7	16	16	44	8	0.3	4.3	0.78	97.2	89.9869	66.3682
2015	7	16	16	54	8	0.3	4.3	0.77	99.3	89.9213	64.9189
2015	7	16	17	4	8	0.3	4.3	0.8	100.6	89.9213	67.4373
2015	7	16	17	14	8	0.3	4.3	0.77	96.9	89.9213	64.9189
2015	7	16	17	24	8	0.3	4.3	0.77	97.9	89.9213	64.639
2015	7	16	17	34	8	0.3	4.3	0.73	99	89.9869	61.8876
2015	7	16	17	44	8	0.3	4.3	0.77	100.1	89.8556	64.5901
2015	7	16	17	54	8	0.3	4.3	0.78	98.5	89.8556	65.429
2015	7	16	18	4	8	0.3	4.3	0.77	96.9	89.8556	64.8698
2015	7	16	18	14	8	0.3	4.3	0.79	99.6	89.8556	65.9882
2015	7	16	18	24	8	0.3	4.3	0.77	99.1	89.9213	64.639
2015	7	16	18	34	8	0.3	4.3	0.77	97.8	89.8556	65.1494
2015	7	16	18	44	8	0.3	4.3	0.77	98.4	89.8556	64.5901
2015	7	16	18	54	8	0.3	4.3	0.78	97.2	89.9213	66.0381
2015	7	16	19	4	8	0.3	4.3	0.8	98.3	89.9213	67.4372
2015	7	16	19	14	8	0.3	4.3	0.78	97.5	89.9213	66.0381
2015	7	16	19	24	8	0.3	4.3	0.77	98.5	89.9213	65.1987
2015	7	16	19	34	8	0.3	4.3	0.77	98.4	89.9213	64.639
2015	7	16	19	44	8	0.3	4.3	0.75	101.8	89.9213	62.9601
2015	7	16	19	54	8	0.3	4.3	0.77	100.3	89.9213	64.639
2015	7	16	20	4	8	0.3	4.3	0.76	97.4	89.9213	64.639
2015	7	16	20	14	8	0.3	4.3	0.75	97.1	89.9213	63.2399
2015	7	16	20	24	8	0.3	4.3	0.76	99.9	89.9213	64.0793
2015	7	16	20	34	8	0.3	4.3	0.77	98.6	89.9213	64.9188
2015	7	16	20	44	8	0.3	4.3	0.76	97.4	89.8556	64.59
2015	7	16	20	54	8	0.3	4.3	0.76	95.7	89.9213	64.6389
2015	7	16	21	4	8	0.3	4.3	0.75	98.8	89.9213	63.2398
2015	7	16	21	14	8	0.3	4.3	0.78	98	89.9213	65.4784
2015	7	16	21	24	8	0.3	4.3	0.75	97.5	89.9213	63.7995
2015	7	16	21	34	8	0.3	4.3	0.75	96.3	89.9213	63.7995
2015	7	16	21	44	8	0.3	4.3	0.75	97.5	89.8556	63.7512
2015	7	16	21	54	8	0.3	4.3	0.77	97.4	89.8556	64.8696
2015	7	16	22	4	8	0.3	4.3	0.77	96.9	89.9213	64.9187
2015	7	16	22	14	8	0.3	4.3	0.75	98.8	89.9213	63.5196
2015	7	16	22	24	8	0.3	4.3	0.77	96.2	89.9213	64.9187
2015	7	16	22	34	8	0.3	4.3	0.71	96.1	89.9213	59.8819
2015	7	16	22	44	8	0.3	4.3	0.79	95.5	89.9213	66.8775
2015	7	16	22	54	8	0.3	4.3	0.74	96.4	89.9213	62.6801
2015	7	16	23	4	8	0.3	4.3	0.77	94.9	89.9213	65.1985
2015	7	16	23	14	8	0.3	4.3	0.75	97	89.9213	63.7994
2015	7	16	23	24	8	0.3	4.3	0.78	98.7	89.9869	65.5279
2015	7	16	23	34	8	0.3	4.3	0.77	97.5	89.9869	65.5279
2015	7	16	23	44	8	0.3	4.3	0.76	96.5	89.9869	64.1277

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	16	23	54	8	0.3	4.3	0.78	96.6	89.9869	65.8079
2015	7	17	0	4	8	0.3	4.3	0.76	95.7	89.9869	64.9678
2015	7	17	0	14	8	0.3	4.3	0.77	96.6	89.9869	64.9678
2015	7	17	0	24	8	0.3	4.3	0.75	95	89.9869	64.1277
2015	7	17	0	34	8	0.3	4.3	0.78	97.2	89.9869	66.088
2015	7	17	0	44	8	0.3	4.3	0.75	95.2	89.9869	64.1277
2015	7	17	0	54	8	0.3	4.3	0.79	99.3	89.9869	66.6481
2015	7	17	1	4	8	0.3	4.3	0.76	95.4	89.9869	64.9679
2015	7	17	1	14	8	0.3	4.3	0.76	95.2	89.9869	64.9679
2015	7	17	1	24	8	0.3	4.3	0.78	96	89.9869	66.368
2015	7	17	1	34	8	0.3	4.3	0.79	96.9	89.9869	66.6481
2015	7	17	1	44	8	0.3	4.3	0.75	95	89.9869	63.5677
2015	7	17	1	54	8	0.3	4.3	0.76	97.9	89.9869	64.4078
2015	7	17	2	4	8	0.3	4.3	0.75	96.3	89.9869	63.8478
2015	7	17	2	14	8	0.3	4.3	0.78	96.3	89.9869	66.0881
2015	7	17	2	24	8	0.3	4.3	0.75	98.3	89.9869	63.5678
2015	7	17	2	34	8	0.3	4.3	0.75	97.1	89.9869	63.2878
2015	7	17	2	44	8	0.3	4.3	0.75	95	89.9869	63.8478
2015	7	17	2	54	8	0.3	4.3	0.77	96.1	89.9869	65.248
2015	7	17	3	4	8	0.3	4.3	0.77	97.1	89.9869	65.248
2015	7	17	3	14	8	0.3	4.3	0.75	97.5	89.9869	63.5678
2015	7	17	3	24	8	0.3	4.3	0.76	94.9	89.9869	64.968
2015	7	17	3	34	8	0.3	4.3	0.8	96.6	89.9869	67.7684
2015	7	17	3	44	8	0.3	4.3	0.75	98.1	89.9869	63.2878
2015	7	17	3	54	8	0.3	4.3	0.74	97.6	89.9869	62.7278
2015	7	17	4	4	8	0.3	4.3	0.76	97.4	89.9869	64.688
2015	7	17	4	14	8	0.3	4.3	0.71	96.7	89.9869	59.9275
2015	7	17	4	24	8	0.3	4.3	0.74	97.1	89.9869	62.7278
2015	7	17	4	34	8	0.3	4.3	0.72	96.8	89.9869	60.7676
2015	7	17	4	44	8	0.3	4.3	0.75	95.8	89.9869	63.568
2015	7	17	4	54	8	0.3	4.3	0.75	94.5	89.9869	63.568
2015	7	17	5	4	8	0.3	4.3	0.73	96.2	89.9869	61.8878
2015	7	17	5	14	8	0.3	4.3	0.76	97.7	89.9869	64.1281
2015	7	17	5	24	8	0.3	4.3	0.74	97.4	89.9869	62.4479
2015	7	17	5	34	8	0.3	4.3	0.75	96.3	89.9869	63.288
2015	7	17	5	44	8	0.3	4.3	0.77	94.9	89.9869	65.2483
2015	7	17	5	54	8	0.3	4.3	0.73	95.9	89.9869	62.1679
2015	7	17	6	4	8	0.3	4.3	0.78	97.3	89.9869	65.8084
2015	7	17	6	14	8	0.3	4.3	0.77	96.8	89.9869	65.5283
2015	7	17	6	24	8	0.3	4.3	0.74	96.1	89.9869	62.448
2015	7	17	6	34	8	0.3	4.3	0.78	97.8	89.9869	65.8084
2015	7	17	6	44	8	0.3	4.3	0.74	97.6	89.9869	62.728
2015	7	17	6	54	8	0.3	4.3	0.77	95.9	89.9869	65.2484
2015	7	17	7	4	8	0.3	4.3	0.78	95.8	89.9869	66.6486
2015	7	17	7	14	8	0.3	4.3	0.74	97.3	89.9869	63.0081
2015	7	17	7	24	8	0.3	4.3	0.78	95.8	89.9869	66.0885
2015	7	17	7	34	8	0.3	4.3	0.76	96.2	89.9213	64.3596

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	17	7	44	8	0.3	4.3	0.77	98.8	89.9869	64.9684
2015	7	17	7	54	8	0.3	4.3	0.73	97.5	89.9869	61.888
2015	7	17	8	4	8	0.3	4.3	0.76	97.4	89.9213	64.3596
2015	7	17	8	14	8	0.3	4.3	0.76	97.7	89.9213	64.0798
2015	7	17	8	24	8	0.3	4.3	0.77	94.9	89.9213	65.1991
2015	7	17	8	34	8	0.3	4.3	0.75	96.8	89.9213	63.2403
2015	7	17	8	44	8	0.3	4.3	0.75	96.8	89.9213	63.7999
2015	7	17	8	54	8	0.3	4.3	0.75	95.3	89.9213	63.5201
2015	7	17	9	4	8	0.3	4.3	0.78	96.5	89.9213	66.0385
2015	7	17	9	14	8	0.3	4.3	0.76	96	89.9213	64.3595
2015	7	17	9	24	8	0.3	4.3	0.76	97.4	89.9213	64.3595
2015	7	17	9	34	8	0.3	4.3	0.76	99.7	89.9213	63.7999
2015	7	17	9	44	8	0.3	4.3	0.76	100	89.9213	63.52
2015	7	17	9	54	8	0.3	4.3	0.78	98	89.9213	65.7586
2015	7	17	10	4	8	0.3	4.3	0.76	100.6	89.9213	64.0797
2015	7	17	10	14	8	0.3	4.3	0.78	99.7	89.9213	65.7586
2015	7	17	10	24	8	0.3	4.3	0.79	101.1	89.9213	65.7586
2015	7	17	10	34	8	0.3	4.3	0.74	101.5	89.9213	61.841
2015	7	17	10	44	8	0.3	4.3	0.75	99.8	89.8556	62.9127
2015	7	17	10	54	8	0.3	4.3	0.77	102.3	89.8556	64.3107
2015	7	17	11	4	8	0.3	4.3	0.79	100.5	89.8556	66.5476
2015	7	17	11	14	8	0.3	4.3	0.78	100.6	89.8556	65.7087
2015	7	17	11	24	8	0.3	4.3	0.79	101.7	89.79	65.9384
2015	7	17	11	34	8	0.3	4.3	0.79	99.8	89.8556	66.2679
2015	7	17	11	44	8	0.3	4.3	0.77	102.6	89.79	63.9826
2015	7	17	11	54	8	0.3	4.3	0.74	98.9	89.7244	62.2589
2015	7	17	12	4	8	0.3	4.3	0.76	104.5	89.7244	62.8173
2015	7	17	12	14	8	0.3	4.3	0.76	101	89.6588	63.0486
2015	7	17	12	24	8	0.3	4.3	0.74	101.8	89.7244	61.7005
2015	7	17	12	34	8	0.3	4.3	0.76	101	89.6588	63.0486
2015	7	17	12	44	8	0.3	3.9	0.78	102.7	89.5932	64.3945
2015	7	17	12	54	8	0.3	4.3	0.76	98.2	89.6588	63.8855
2015	7	17	13	4	8	0.3	3.9	0.78	102.4	89.5932	64.3945
2015	7	17	13	14	8	0.3	3.9	0.74	102.5	89.5932	61.6069
2015	7	17	13	24	8	0.3	3.9	0.75	98.8	89.5276	63.2314
2015	7	17	13	34	8	0.3	3.9	0.77	100.3	89.5276	64.3456
2015	7	17	13	44	8	0.3	3.9	0.73	96.2	89.5276	61.2815
2015	7	17	13	54	8	0.3	3.9	0.75	101.4	89.5276	62.3957
2015	7	17	14	4	8	0.3	3.9	0.75	97.8	89.5276	63.2314
2015	7	17	14	14	8	0.3	3.9	0.77	96.8	89.462	65.1317
2015	7	17	14	24	8	0.3	3.9	0.74	95.9	89.462	62.3483
2015	7	17	14	34	8	0.3	3.9	0.74	99.7	89.3963	61.7446
2015	7	17	14	44	8	0.3	3.9	0.75	99.1	89.3307	62.8093
2015	7	17	14	54	8	0.3	3.9	0.74	100	89.3963	61.7446
2015	7	17	15	4	8	0.3	3.9	0.74	99.5	89.3307	61.6976
2015	7	17	15	14	8	0.3	3.9	0.73	100.6	89.3307	61.1418
2015	7	17	15	24	8	0.3	3.9	0.71	96.1	89.3307	60.0301

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	17	15	34	8	0.3	3.9	0.76	98.7	89.3307	63.3651
2015	7	17	15	44	8	0.3	3.9	0.78	102.7	89.3307	64.1989
2015	7	17	15	54	8	0.3	3.9	0.79	95	89.2651	66.3716
2015	7	17	16	4	8	0.3	3.9	0.74	98.4	89.2651	62.2061
2015	7	17	16	14	8	0.3	3.9	0.75	102.7	89.1995	61.6037
2015	7	17	16	24	8	0.3	3.9	0.75	97.8	89.1995	62.9911
2015	7	17	16	34	8	0.3	3.9	0.76	97.9	89.2651	63.8723
2015	7	17	16	44	8	0.3	3.9	0.73	98	89.1995	61.3262
2015	7	17	16	54	8	0.3	3.9	0.75	98.6	89.1995	62.4361
2015	7	17	17	4	8	0.3	3.9	0.77	96.1	89.1995	64.9336
2015	7	17	17	14	8	0.3	3.9	0.73	101.2	89.1339	60.1703
2015	7	17	17	24	8	0.3	3.9	0.74	97.6	89.1339	62.1113
2015	7	17	17	34	8	0.3	3.9	0.76	96.5	89.0683	63.4492
2015	7	17	17	44	8	0.3	3.9	0.75	98.8	89.1339	62.6658
2015	7	17	17	54	8	0.3	3.9	0.77	98.6	89.1339	64.3295
2015	7	17	18	4	8	0.3	3.9	0.73	97	89.1339	61.0021
2015	7	17	18	14	8	0.3	3.9	0.75	97.8	89.0683	62.895
2015	7	17	18	24	8	0.3	3.9	0.76	95.7	89.0683	63.4492
2015	7	17	18	34	8	0.3	3.9	0.72	96.3	89.0683	60.4014
2015	7	17	18	44	8	0.3	3.9	0.76	95.7	89.0683	63.4492
2015	7	17	18	54	8	0.3	3.9	0.75	97.8	89.0683	62.618
2015	7	17	19	4	8	0.3	3.9	0.76	96	89.0026	63.6775
2015	7	17	19	14	8	0.3	3.9	0.73	95.2	89.0026	61.1858
2015	7	17	19	24	8	0.3	3.9	0.74	98.4	89.0026	62.0164
2015	7	17	19	34	8	0.3	3.9	0.74	97.6	89.0026	62.0164
2015	7	17	19	44	8	0.3	3.9	0.74	95.9	89.0026	62.0164
2015	7	17	19	54	8	0.3	3.9	0.74	96.4	89.0026	61.7395
2015	7	17	20	4	8	0.3	3.9	0.74	96.6	89.0026	62.0163
2015	7	17	20	14	8	0.3	3.9	0.76	98.7	89.0026	63.1238
2015	7	17	20	24	8	0.3	3.9	0.76	95.5	89.0026	63.6775
2015	7	17	20	34	8	0.3	3.9	0.75	96	88.937	63.0755
2015	7	17	20	44	8	0.3	3.9	0.75	98.3	88.937	62.7988
2015	7	17	20	54	8	0.3	3.9	0.7	97.3	88.937	58.6491
2015	7	17	21	4	8	0.3	3.9	0.73	95.9	88.8714	61.3686
2015	7	17	21	14	8	0.3	3.9	0.73	95.5	88.937	60.8623
2015	7	17	21	24	8	0.3	3.9	0.77	96.2	88.937	64.182
2015	7	17	21	34	8	0.3	3.9	0.71	92.9	88.8714	59.9864
2015	7	17	21	44	8	0.3	3.9	0.72	97.1	88.8714	60.2628
2015	7	17	21	54	8	0.3	3.9	0.72	98.4	88.8058	59.9405
2015	7	17	22	4	8	0.3	3.9	0.75	96.3	88.8714	62.4743
2015	7	17	22	14	8	0.3	3.9	0.74	95.9	88.8058	61.874
2015	7	17	22	24	8	0.3	3.9	0.72	95.5	88.8058	60.4929
2015	7	17	22	34	8	0.3	3.9	0.73	94.4	88.8058	61.5978
2015	7	17	22	44	8	0.3	3.9	0.78	96.1	88.8058	64.9125
2015	7	17	22	54	8	0.3	3.9	0.72	97.1	88.8058	60.2167
2015	7	17	23	4	8	0.3	3.9	0.69	99	88.8058	57.7306
2015	7	17	23	14	8	0.3	3.9	0.73	97.5	88.8058	60.7691

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	17	23	24	8	0.3	3.9	0.76	97.7	88.8714	63.3036
2015	7	17	23	34	8	0.3	3.9	0.73	92.8	88.8058	61.3216
2015	7	17	23	44	8	0.3	3.9	0.75	97.8	88.7402	62.1026
2015	7	17	23	54	8	0.3	3.9	0.72	97.9	88.8058	59.9404
2015	7	18	0	4	8	0.3	3.9	0.73	96.2	88.7402	61.2746
2015	7	18	0	14	8	0.3	3.9	0.76	99.5	88.7402	62.6546
2015	7	18	0	24	8	0.3	3.9	0.73	93.4	88.7402	60.9986
2015	7	18	0	34	8	0.3	3.9	0.75	95.3	88.7402	62.9306
2015	7	18	0	44	8	0.3	3.9	0.74	96.1	88.7402	62.1026
2015	7	18	0	54	8	0.3	3.9	0.75	97.8	88.8058	62.7027
2015	7	18	1	4	8	0.3	3.9	0.74	96.4	88.8058	61.874
2015	7	18	1	14	8	0.3	3.9	0.7	97.3	88.8058	58.5594
2015	7	18	1	24	8	0.3	3.9	0.73	96.2	88.8714	61.3686
2015	7	18	1	34	8	0.3	3.9	0.74	95.1	88.8714	61.9215
2015	7	18	1	44	8	0.3	3.9	0.72	97.6	88.8058	60.2167
2015	7	18	1	54	8	0.3	3.9	0.76	100	88.8058	62.7027
2015	7	18	2	4	8	0.3	3.9	0.76	96.2	88.6745	63.1582
2015	7	18	2	14	8	0.3	3.9	0.76	97.9	88.7402	63.4827
2015	7	18	2	24	8	0.3	3.9	0.73	93.4	88.7402	61.2746
2015	7	18	2	34	8	0.3	3.9	0.75	96.8	88.7402	62.6547
2015	7	18	2	44	8	0.3	3.9	0.76	96.9	88.6745	63.7098
2015	7	18	2	54	8	0.3	3.9	0.77	95.4	88.6745	64.2615
2015	7	18	3	4	8	0.3	3.9	0.72	95.5	88.6745	59.8487
2015	7	18	3	14	8	0.3	3.9	0.73	96.4	88.6745	61.2277
2015	7	18	3	24	8	0.3	3.9	0.72	96.8	88.6745	60.4003
2015	7	18	3	34	8	0.3	3.9	0.73	94.6	88.6745	61.2277
2015	7	18	3	44	8	0.3	3.9	0.77	96.1	88.6745	64.5373
2015	7	18	3	54	8	0.3	3.9	0.7	94.3	88.6745	59.0213
2015	7	18	4	4	8	0.3	3.9	0.72	96.3	88.6745	60.1245
2015	7	18	4	14	8	0.3	3.9	0.75	97.2	88.6745	62.8826
2015	7	18	4	24	8	0.3	3.9	0.74	96.8	88.6089	62.0076
2015	7	18	4	34	8	0.3	3.9	0.73	94.4	88.6089	60.9052
2015	7	18	4	44	8	0.3	3.9	0.75	96.6	88.6745	62.331
2015	7	18	4	54	8	0.3	3.9	0.73	95.9	88.6089	61.1809
2015	7	18	5	4	8	0.3	3.9	0.72	96	88.6089	60.3541
2015	7	18	5	14	8	0.3	3.9	0.71	94.5	88.6089	59.5273
2015	7	18	5	24	8	0.3	3.9	0.75	94.3	88.6089	62.8344
2015	7	18	5	34	8	0.3	3.9	0.78	97.8	88.6089	64.7636
2015	7	18	5	44	8	0.3	3.9	0.73	95.1	88.6089	61.4565
2015	7	18	5	54	8	0.3	3.9	0.77	96.1	88.6089	64.2124
2015	7	18	6	4	8	0.3	3.9	0.73	95.1	88.5433	61.4094
2015	7	18	6	14	8	0.3	3.9	0.72	96.5	88.5433	60.3078
2015	7	18	6	24	8	0.3	3.9	0.69	95.4	88.5433	57.8295
2015	7	18	6	34	8	0.3	3.9	0.72	94.4	88.5433	60.5832
2015	7	18	6	44	8	0.3	3.9	0.76	96.5	88.5433	63.0617
2015	7	18	6	54	8	0.3	3.9	0.75	96.8	88.5433	62.2356
2015	7	18	7	4	8	0.3	3.9	0.73	97.7	88.5433	60.8587

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	18	7	14	8	0.3	3.9	0.73	92.8	88.5433	61.1341
2015	7	18	7	24	8	0.3	3.9	0.75	96.8	88.5433	62.7863
2015	7	18	7	34	8	0.3	3.9	0.76	99.2	88.5433	62.7863
2015	7	18	7	44	8	0.3	3.9	0.76	95.9	88.5433	63.6125
2015	7	18	7	54	8	0.3	3.9	0.73	96	88.5433	60.5833
2015	7	18	8	4	8	0.3	3.9	0.73	96.7	88.4777	60.5367
2015	7	18	8	14	8	0.3	3.9	0.75	97.3	88.4777	62.1877
2015	7	18	8	24	8	0.3	3.9	0.74	97.3	88.4777	61.9126
2015	7	18	8	34	8	0.3	3.9	0.74	97.1	88.4777	61.6374
2015	7	18	8	44	8	0.3	3.9	0.72	97.1	88.4777	59.9864
2015	7	18	8	54	8	0.3	3.9	0.76	99.1	88.4777	63.2884
2015	7	18	9	4	8	0.3	3.9	0.76	100.2	88.4121	62.4148
2015	7	18	9	14	8	0.3	3.9	0.76	99.9	88.4121	62.9648
2015	7	18	9	24	8	0.3	3.9	0.78	100.9	88.4121	64.0646
2015	7	18	9	34	8	0.3	3.9	0.75	100.4	88.4121	61.59
2015	7	18	9	44	8	0.3	3.9	0.75	101.6	88.4121	61.59
2015	7	18	9	54	8	0.3	3.9	0.74	97.7	88.4121	61.315
2015	7	18	10	4	8	0.3	3.9	0.74	97.6	88.4121	61.5899
2015	7	18	10	14	8	0.3	3.9	0.75	98.1	88.3465	61.8172
2015	7	18	10	24	8	0.3	3.9	0.74	98.9	88.3465	61.2677
2015	7	18	10	34	8	0.3	3.9	0.74	100.7	88.3465	61.2677
2015	7	18	10	44	8	0.3	3.9	0.73	97.7	88.3465	60.993
2015	7	18	10	54	8	0.3	3.9	0.73	96.7	88.3465	60.993
2015	7	18	11	4	8	0.3	3.9	0.75	100.8	88.2808	61.7695
2015	7	18	11	14	8	0.3	3.9	0.72	98.2	88.2808	59.2988
2015	7	18	11	24	8	0.3	3.9	0.72	98.7	88.2152	59.253
2015	7	18	11	34	8	0.3	3.9	0.72	101.5	88.1496	59.2073
2015	7	18	11	44	8	0.3	3.9	0.74	100.5	88.2152	60.6246
2015	7	18	11	54	8	0.3	3.9	0.73	102.5	88.1496	59.4814
2015	7	18	12	4	8	0.3	3.9	0.75	102.4	88.1496	61.126
2015	7	18	12	14	8	0.3	3.9	0.71	102.6	88.084	57.7921
2015	7	18	12	24	8	0.3	3.9	0.76	99.4	87.9528	62.8987
2015	7	18	12	34	8	0.3	3.9	0.73	102	88.0184	59.3895
2015	7	18	12	44	8	0.3	3.9	0.72	98.1	88.0184	59.6631
2015	7	18	12	54	8	0.3	3.9	0.75	98.8	87.9528	61.8048
2015	7	18	13	4	8	0.3	3.9	0.7	103.3	87.8871	56.8383
2015	7	18	13	14	8	0.3	3.9	0.71	98.2	87.9528	58.5232
2015	7	18	13	24	8	0.3	3.9	0.74	100.7	87.8871	60.9372
2015	7	18	13	34	8	0.3	3.9	0.73	102.5	87.8215	59.2518
2015	7	18	13	44	8	0.3	3.9	0.71	96.3	87.8871	59.0244
2015	7	18	13	54	8	0.3	3.9	0.7	96.7	87.8215	58.1596
2015	7	18	14	4	8	0.3	3.9	0.72	98.7	87.7559	58.933
2015	7	18	14	14	8	0.3	3.9	0.74	94.1	87.6903	61.3409
2015	7	18	14	24	8	0.3	3.9	0.71	96.6	87.7559	58.933
2015	7	18	14	34	8	0.3	3.9	0.7	96	87.8215	57.6135
2015	7	18	14	44	8	0.3	3.9	0.7	96.4	87.7559	58.1145
2015	7	18	14	54	8	0.3	3.9	0.7	98.6	87.6903	57.5242

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	18	15	4	8	0.3	3.9	0.7	96.8	87.8215	57.6135
2015	7	18	15	14	8	0.3	3.9	0.7	100.2	87.6247	57.4795
2015	7	18	15	24	8	0.3	3.9	0.73	99.3	87.6903	59.7052
2015	7	18	15	34	8	0.3	3.9	0.69	98.2	87.6247	56.9347
2015	7	18	15	44	8	0.3	3.9	0.7	98.9	87.6247	57.4795
2015	7	18	15	54	8	0.3	3.9	0.72	95.2	87.6247	59.6588
2015	7	18	16	4	8	0.3	3.9	0.71	98.5	87.6247	58.0243
2015	7	18	16	14	8	0.3	3.9	0.71	98.2	87.4934	58.4782
2015	7	18	16	24	8	0.3	3.9	0.7	97.6	87.5591	57.4348
2015	7	18	16	34	8	0.3	3.9	0.74	94.8	87.4934	61.4701
2015	7	18	16	44	8	0.3	3.9	0.68	96.3	87.5591	56.3461
2015	7	18	16	54	8	0.3	3.9	0.73	94.1	87.4934	60.1102
2015	7	18	17	4	8	0.3	3.9	0.73	95.7	87.4934	59.8382
2015	7	18	17	14	8	0.3	3.9	0.74	95.3	87.4934	61.4702
2015	7	18	17	24	8	0.3	3.9	0.75	97.5	87.3622	61.9176
2015	7	18	17	34	8	0.3	3.9	0.72	97.4	87.5591	59.0682
2015	7	18	17	44	8	0.3	3.9	0.72	95.8	87.4278	59.2481
2015	7	18	17	54	8	0.3	3.9	0.75	98.8	87.4278	61.1506
2015	7	18	18	4	8	0.3	3.9	0.73	95.7	87.3622	59.7451
2015	7	18	18	14	8	0.3	3.9	0.71	95.3	87.3622	58.9304
2015	7	18	18	24	8	0.3	3.9	0.73	95.7	87.3622	59.7451
2015	7	18	18	34	8	0.3	3.9	0.74	95.6	87.3622	61.1029
2015	7	18	18	44	8	0.3	3.9	0.73	94.4	87.3622	60.0167
2015	7	18	18	54	8	0.3	3.9	0.7	99.4	87.2966	57.2563
2015	7	18	19	4	8	0.3	3.9	0.71	96.6	87.231	58.5674
2015	7	18	19	14	8	0.3	3.9	0.72	97.6	87.2966	58.6131
2015	7	18	19	24	8	0.3	3.9	0.74	96.4	87.2966	60.784
2015	7	18	19	34	8	0.3	3.9	0.75	96.8	87.3622	61.9176
2015	7	18	19	44	8	0.3	3.9	0.73	96.5	87.2966	59.6985
2015	7	18	19	54	8	0.3	3.9	0.72	97.3	87.2966	59.4272
2015	7	18	20	4	8	0.3	3.9	0.72	97.6	87.231	58.5674
2015	7	18	20	14	8	0.3	3.9	0.73	97.2	87.231	59.9231
2015	7	18	20	24	8	0.3	3.9	0.7	97	87.231	57.4828
2015	7	18	20	34	8	0.3	3.9	0.72	97.6	87.1654	59.0635
2015	7	18	20	44	8	0.3	3.9	0.71	95	87.1654	58.5216
2015	7	18	20	54	8	0.3	3.9	0.71	97.4	87.231	58.5673
2015	7	18	21	4	8	0.3	3.9	0.71	95.1	87.1654	58.2507
2015	7	18	21	14	8	0.3	3.9	0.7	97	87.231	57.4828
2015	7	18	21	24	8	0.3	3.9	0.72	94.4	87.1654	59.6054
2015	7	18	21	34	8	0.3	3.9	0.69	95.2	87.1654	56.896
2015	7	18	21	44	8	0.3	3.9	0.7	99.4	87.1654	57.4379
2015	7	18	21	54	8	0.3	3.9	0.73	99	87.0997	59.8295
2015	7	18	22	4	8	0.3	3.9	0.73	98	87.0341	59.7827
2015	7	18	22	14	8	0.3	3.9	0.72	99.5	87.0341	58.1597
2015	7	18	22	24	8	0.3	3.9	0.71	98.2	87.0341	58.1597
2015	7	18	22	34	8	0.3	3.9	0.72	96.8	87.0341	59.2417
2015	7	18	22	44	8	0.3	3.9	0.73	95.9	87.0341	60.0533

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	18	22	54	8	0.3	3.9	0.71	96.6	87.0341	58.1597
2015	7	18	23	4	8	0.3	3.9	0.72	96.1	87.0341	58.7007
2015	7	18	23	14	8	0.3	3.9	0.71	96.7	87.0341	57.8892
2015	7	18	23	24	8	0.3	3.9	0.76	96.2	87.0341	62.2173
2015	7	18	23	34	8	0.3	3.9	0.7	97.6	87.0341	57.0776
2015	7	18	23	44	8	0.3	3.9	0.73	95.2	87.0341	59.7828
2015	7	18	23	54	8	0.3	3.9	0.74	97.4	87.0341	60.3238
2015	7	19	0	4	8	0.3	3.9	0.72	96.6	87.0341	58.7007
2015	7	19	0	14	8	0.3	3.9	0.69	98.5	87.0341	56.2661
2015	7	19	0	24	8	0.3	3.9	0.72	97.3	86.9685	59.1954
2015	7	19	0	34	8	0.3	3.9	0.72	94.7	86.9685	59.1954
2015	7	19	0	44	8	0.3	3.9	0.71	95.3	86.9685	58.3845
2015	7	19	0	54	8	0.3	3.9	0.71	97.2	86.9685	58.1143
2015	7	19	1	4	8	0.3	3.9	0.69	94.6	86.9685	57.0331
2015	7	19	1	14	8	0.3	3.9	0.75	95.8	86.9685	61.0876
2015	7	19	1	24	8	0.3	3.9	0.73	97.8	86.9685	59.4658
2015	7	19	1	34	8	0.3	3.9	0.71	97.2	86.9685	58.1143
2015	7	19	1	44	8	0.3	3.9	0.73	96.2	86.9685	59.4658
2015	7	19	1	54	8	0.3	3.9	0.68	96.7	86.9685	55.4113
2015	7	19	2	4	8	0.3	3.9	0.72	99.7	86.9685	58.3846
2015	7	19	2	14	8	0.3	3.9	0.74	97.4	86.9685	60.2767
2015	7	19	2	24	8	0.3	3.9	0.73	96.2	86.9685	59.4658
2015	7	19	2	34	8	0.3	3.9	0.72	97.4	86.9685	58.655
2015	7	19	2	44	8	0.3	3.9	0.7	99.5	86.9685	56.7629
2015	7	19	2	54	8	0.3	3.9	0.72	97.9	86.9685	58.3847
2015	7	19	3	4	8	0.3	3.9	0.68	94.7	86.9685	55.6817
2015	7	19	3	14	8	0.3	3.9	0.7	97.6	86.9685	56.7629
2015	7	19	3	24	8	0.3	3.9	0.71	99.1	86.9029	57.5287
2015	7	19	3	34	8	0.3	3.9	0.73	98.8	86.9029	59.4194
2015	7	19	3	44	8	0.3	3.9	0.71	98	86.9029	57.7988
2015	7	19	3	54	8	0.3	3.9	0.71	97.9	86.9029	58.069
2015	7	19	4	4	8	0.3	3.9	0.74	98.9	86.9029	60.2297
2015	7	19	4	14	8	0.3	3.9	0.71	95.3	86.9029	58.6092
2015	7	19	4	24	8	0.3	3.9	0.73	97.5	86.9029	59.6895
2015	7	19	4	34	8	0.3	3.9	0.69	95.7	86.9029	56.7186
2015	7	19	4	44	8	0.3	3.9	0.72	97.4	86.9029	58.6092
2015	7	19	4	54	8	0.3	3.9	0.72	95.2	86.9029	58.8793
2015	7	19	5	4	8	0.3	3.9	0.72	96.6	86.9029	58.6092
2015	7	19	5	14	8	0.3	3.9	0.71	98.8	86.9029	57.799
2015	7	19	5	24	8	0.3	3.9	0.72	99.2	86.9029	58.6092
2015	7	19	5	34	8	0.3	3.9	0.71	97.5	86.8373	57.7537
2015	7	19	5	44	8	0.3	3.9	0.69	99.3	86.8373	56.1345
2015	7	19	5	54	8	0.3	3.9	0.7	97.3	86.8373	56.9441
2015	7	19	6	4	8	0.3	3.9	0.72	96.8	86.8373	59.1031
2015	7	19	6	14	8	0.3	3.9	0.7	98.9	86.8373	56.6742
2015	7	19	6	24	8	0.3	3.9	0.69	96.8	86.8373	56.6742
2015	7	19	6	34	8	0.3	3.9	0.72	95.8	86.8373	58.8333

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	19	6	44	8	0.3	3.9	0.7	97.2	86.8373	57.4839
2015	7	19	6	54	8	0.3	3.9	0.71	97.7	86.8373	57.7538
2015	7	19	7	4	8	0.3	3.9	0.74	98.6	86.8373	60.4525
2015	7	19	7	14	8	0.3	3.9	0.74	98.4	86.8373	60.4525
2015	7	19	7	24	8	0.3	3.9	0.7	94.3	86.8373	57.4839
2015	7	19	7	34	8	0.3	3.9	0.69	96.8	86.8373	56.4044
2015	7	19	7	44	8	0.3	3.9	0.71	98	86.8373	57.7537
2015	7	19	7	54	8	0.3	3.9	0.71	96.9	86.8373	57.7538
2015	7	19	8	4	8	0.3	3.9	0.69	98.2	86.8373	56.4043
2015	7	19	8	14	8	0.3	3.9	0.72	97.9	86.7717	58.2478
2015	7	19	8	24	8	0.3	3.9	0.75	99.1	86.7717	60.6747
2015	7	19	8	34	8	0.3	3.9	0.7	99.5	86.7717	56.6298
2015	7	19	8	44	8	0.3	3.9	0.7	95.7	86.7717	57.1691
2015	7	19	8	54	8	0.3	3.9	0.73	98.2	86.7717	59.5961
2015	7	19	9	4	8	0.3	3.9	0.73	99	86.7717	59.3264
2015	7	19	9	14	8	0.3	3.9	0.72	97.6	86.7717	58.2477
2015	7	19	9	24	8	0.3	3.9	0.73	100.9	86.7717	59.0567
2015	7	19	9	34	8	0.3	3.9	0.73	102.3	86.7717	58.2477
2015	7	19	9	44	8	0.3	3.9	0.71	99.1	86.7717	57.4387
2015	7	19	9	54	8	0.3	3.9	0.73	101.4	86.7717	58.787
2015	7	19	10	4	8	0.3	3.9	0.71	97.1	86.7717	58.2477
2015	7	19	10	14	8	0.3	3.9	0.74	100.5	86.7717	59.8657
2015	7	19	10	24	8	0.3	3.9	0.74	99.4	86.7717	60.1353
2015	7	19	10	34	8	0.3	3.9	0.7	97.2	86.706	57.3936
2015	7	19	10	44	8	0.3	3.9	0.71	100.4	86.706	57.3935
2015	7	19	10	54	8	0.3	3.9	0.74	96.6	86.706	60.3575
2015	7	19	11	4	8	0.3	3.9	0.71	97.7	86.706	57.9324
2015	7	19	11	14	8	0.3	3.9	0.72	93.1	86.706	59.2797
2015	7	19	11	24	8	0.3	3.9	0.73	95.5	86.6404	59.2331
2015	7	19	11	34	8	0.3	3.9	0.72	99.9	86.6404	58.4254
2015	7	19	11	44	8	0.3	3.9	0.72	100.3	86.6404	57.8869
2015	7	19	11	54	8	0.3	3.9	0.73	100.6	86.6404	58.9639
2015	7	19	12	4	8	0.3	3.9	0.73	99.8	86.5748	58.9176
2015	7	19	12	14	8	0.3	3.9	0.71	99.8	86.5748	57.5724
2015	7	19	12	24	8	0.3	3.9	0.73	100.4	86.5748	58.9175
2015	7	19	12	34	8	0.3	3.9	0.72	98.9	86.5092	58.6024
2015	7	19	12	44	8	0.3	3.9	0.74	99.9	86.4436	59.8993
2015	7	19	12	54	8	0.3	3.9	0.73	99.8	86.378	59.0469
2015	7	19	13	4	8	0.3	3.9	0.73	98	86.378	59.0469
2015	7	19	13	14	8	0.3	3.9	0.71	103.1	86.378	56.6313
2015	7	19	13	24	8	0.3	3.9	0.72	97.8	86.3123	58.4639
2015	7	19	13	34	8	0.3	3.9	0.73	101.1	86.3123	58.7321
2015	7	19	13	44	8	0.3	3.9	0.7	101.2	86.3123	55.7821
2015	7	19	13	54	8	0.3	3.9	0.73	103.7	86.2467	58.1498
2015	7	19	14	4	8	0.3	3.9	0.73	101.4	86.2467	58.4178
2015	7	19	14	14	8	0.3	3.9	0.74	101.8	86.2467	58.9538
2015	7	19	14	24	8	0.3	3.9	0.72	101	86.2467	57.8819

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	19	14	34	8	0.3	3.9	0.68	100	86.2467	54.9342
2015	7	19	14	44	8	0.3	3.9	0.71	99.2	86.1811	57.5684
2015	7	19	14	54	8	0.3	3.9	0.71	97.8	86.1811	57.0329
2015	7	19	15	4	8	0.3	3.9	0.72	97.6	86.1811	57.8361
2015	7	19	15	14	8	0.3	3.9	0.68	97.2	86.1811	55.4263
2015	7	19	15	24	8	0.3	3.9	0.69	97.9	86.1811	55.6941
2015	7	19	15	34	8	0.3	3.9	0.74	94.6	86.1811	59.9782
2015	7	19	15	44	8	0.3	3.9	0.72	96.1	86.1811	58.1039
2015	7	19	15	54	8	0.3	3.9	0.75	96.3	86.1155	60.4659
2015	7	19	16	4	8	0.3	3.9	0.7	99.7	86.1155	56.4527
2015	7	19	16	14	8	0.3	3.9	0.72	101.3	86.1155	57.5229
2015	7	19	16	24	8	0.3	3.9	0.71	97.4	86.1155	57.7904
2015	7	19	16	34	8	0.3	3.9	0.73	101.1	86.1155	58.5931
2015	7	19	16	44	8	0.3	3.9	0.73	97.8	86.1155	58.8606
2015	7	19	16	54	8	0.3	3.9	0.71	101	86.0499	56.408
2015	7	19	17	4	8	0.3	3.9	0.72	98.9	86.0499	58.2794
2015	7	19	17	14	8	0.3	3.9	0.72	101.6	85.7874	57.0289
2015	7	19	17	24	8	0.3	3.9	0.69	97.4	86.1155	55.65
2015	7	19	17	34	8	0.3	3.9	0.7	102.1	86.0499	56.1407
2015	7	19	17	44	8	0.3	3.9	0.72	99.8	86.1155	57.5229
2015	7	19	17	54	8	0.3	3.9	0.7	98.4	86.1155	56.4527
2015	7	19	18	4	8	0.3	3.9	0.72	99.9	86.0499	58.0121
2015	7	19	18	14	8	0.3	3.9	0.72	98.9	86.0499	58.2794
2015	7	19	18	24	8	0.3	3.9	0.71	99.1	86.0499	56.9427
2015	7	19	18	34	8	0.3	3.9	0.71	98	85.9843	57.1648
2015	7	19	18	44	8	0.3	3.9	0.7	96.7	86.0499	56.9427
2015	7	19	18	54	8	0.3	3.9	0.72	97.4	86.0499	58.012
2015	7	19	19	4	8	0.3	3.9	0.72	98.2	86.0499	57.7447
2015	7	19	19	14	8	0.3	3.9	0.7	96.5	86.0499	56.408
2015	7	19	19	24	8	0.3	3.9	0.7	97.9	86.0499	56.1407
2015	7	19	19	34	8	0.3	3.9	0.69	97.1	86.0499	55.8733
2015	7	19	19	44	8	0.3	3.9	0.67	97.9	86.0499	53.7346
2015	7	19	19	54	8	0.3	3.9	0.67	95.1	86.0499	54.002
2015	7	19	20	4	8	0.3	3.9	0.71	98.2	86.0499	57.4773
2015	7	19	20	14	8	0.3	3.9	0.7	97	86.0499	56.408
2015	7	19	20	24	8	0.3	3.9	0.66	94.9	86.0499	53.4673
2015	7	19	20	34	8	0.3	3.9	0.7	96.8	86.0499	56.4079
2015	7	19	20	44	8	0.3	3.9	0.69	98.4	86.0499	55.8733
2015	7	19	20	54	8	0.3	3.9	0.71	95.3	86.0499	58.0119
2015	7	19	21	4	8	0.3	3.9	0.68	98.6	86.0499	55.0712
2015	7	19	21	14	8	0.3	3.9	0.69	96.8	86.0499	55.8732
2015	7	19	21	24	8	0.3	3.9	0.7	97.5	85.9843	56.6304
2015	7	19	21	34	8	0.3	3.9	0.71	97.2	86.0499	57.4772
2015	7	19	21	44	8	0.3	3.9	0.69	95.5	86.0499	55.6059
2015	7	19	21	54	8	0.3	3.9	0.69	95.7	86.0499	55.8732
2015	7	19	22	4	8	0.3	3.9	0.7	99.2	86.0499	56.1405
2015	7	19	22	14	8	0.3	3.9	0.71	96.1	85.9843	57.1646

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	19	22	24	8	0.3	3.9	0.72	96.3	86.0499	58.0119
2015	7	19	22	34	8	0.3	3.9	0.7	95.1	86.0499	56.9425
2015	7	19	22	44	8	0.3	3.9	0.72	96.6	86.0499	58.0119
2015	7	19	22	54	8	0.3	3.9	0.7	96.2	86.0499	56.4078
2015	7	19	23	4	8	0.3	3.9	0.7	96.8	86.0499	56.4078
2015	7	19	23	14	8	0.3	3.9	0.72	96.8	86.0499	58.0118
2015	7	19	23	24	8	0.3	3.9	0.71	98.2	86.0499	57.2098
2015	7	19	23	34	8	0.3	3.9	0.68	98	86.0499	55.0711
2015	7	19	23	44	8	0.3	3.9	0.74	97.4	86.0499	59.6158
2015	7	19	23	54	8	0.3	3.9	0.73	98.6	85.9843	58.5001
2015	7	20	0	4	8	0.3	3.9	0.71	95.3	86.0499	58.0118
2015	7	20	0	14	8	0.3	3.9	0.7	95.4	86.0499	56.4078
2015	7	20	0	24	8	0.3	3.9	0.7	99.7	86.0499	56.4078
2015	7	20	0	34	8	0.3	3.9	0.68	98.4	86.0499	54.5364
2015	7	20	0	44	8	0.3	3.9	0.7	94.8	86.1155	57.2551
2015	7	20	0	54	8	0.3	3.9	0.72	92.3	86.1155	58.8603
2015	7	20	1	4	8	0.3	3.9	0.68	95.8	86.1155	55.1147
2015	7	20	1	14	8	0.3	3.9	0.72	96.8	86.1155	58.0577
2015	7	20	1	24	8	0.3	3.9	0.73	95.2	86.1155	59.1279
2015	7	20	1	34	8	0.3	3.9	0.7	95.1	86.1155	56.4524
2015	7	20	1	44	8	0.3	3.9	0.71	96.1	86.1155	57.7902
2015	7	20	1	54	8	0.3	3.9	0.71	94.7	86.1155	58.0577
2015	7	20	2	4	8	0.3	3.9	0.7	97	86.1155	56.4524
2015	7	20	2	14	8	0.3	3.9	0.72	95.8	86.1811	58.3714
2015	7	20	2	24	8	0.3	3.9	0.72	97.1	86.1811	58.1036
2015	7	20	2	34	8	0.3	3.9	0.71	95	86.1811	58.1036
2015	7	20	2	44	8	0.3	3.9	0.71	95	86.1811	58.1037
2015	7	20	2	54	8	0.3	3.9	0.73	95.9	86.1811	59.1747
2015	7	20	3	4	8	0.3	3.9	0.72	97.1	86.1811	58.3714
2015	7	20	3	14	8	0.3	3.9	0.7	95.4	86.1811	56.4971
2015	7	20	3	24	8	0.3	3.9	0.74	96.1	86.1811	60.2457
2015	7	20	3	34	8	0.3	3.9	0.68	96.6	86.1811	55.1583
2015	7	20	3	44	8	0.3	3.9	0.73	99.3	86.1811	58.6392
2015	7	20	3	54	8	0.3	3.9	0.71	97.5	86.1811	57.3004
2015	7	20	4	4	8	0.3	3.9	0.71	95.3	86.1811	57.3004
2015	7	20	4	14	8	0.3	3.9	0.73	96.5	86.1811	59.1747
2015	7	20	4	24	8	0.3	3.9	0.69	96	86.1811	55.6939
2015	7	20	4	34	8	0.3	3.9	0.69	96.3	86.1811	55.9616
2015	7	20	4	44	8	0.3	3.9	0.66	94.8	86.1811	53.8196
2015	7	20	4	54	8	0.3	3.9	0.69	97.6	86.1811	55.9617
2015	7	20	5	4	8	0.3	3.9	0.71	95.8	86.1811	57.5682
2015	7	20	5	14	8	0.3	3.9	0.69	98.5	86.1811	55.4262
2015	7	20	5	24	8	0.3	3.9	0.69	96	86.1811	56.2294
2015	7	20	5	34	8	0.3	3.9	0.72	96.8	86.1811	58.6393
2015	7	20	5	44	8	0.3	3.9	0.72	97.9	86.1811	58.1038
2015	7	20	5	54	8	0.3	3.9	0.68	99.4	86.1811	55.1584
2015	7	20	6	4	8	0.3	3.9	0.71	99.6	86.1811	57.0327

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	20	6	14	8	0.3	3.9	0.71	101.5	86.1811	56.4972
2015	7	20	6	24	8	0.3	3.9	0.73	98	86.1811	58.9071
2015	7	20	6	34	8	0.3	3.9	0.71	97.7	86.1811	57.5683
2015	7	20	6	44	8	0.3	3.9	0.7	97.5	86.1811	56.765
2015	7	20	6	54	8	0.3	3.9	0.71	98	86.1811	57.3005
2015	7	20	7	4	8	0.3	3.9	0.69	96.5	86.1811	56.2295
2015	7	20	7	14	8	0.3	3.9	0.7	95.4	86.1811	56.4973
2015	7	20	7	24	8	0.3	3.9	0.7	98.4	86.1811	56.4973
2015	7	20	7	34	8	0.3	3.9	0.69	97.3	86.1811	56.2295
2015	7	20	7	44	8	0.3	3.9	0.7	97.3	86.1811	56.4973
2015	7	20	7	54	8	0.3	3.9	0.71	96.9	86.1811	57.3005
2015	7	20	8	4	8	0.3	3.9	0.73	99.8	86.1811	58.6393
2015	7	20	8	14	8	0.3	3.9	0.7	96.7	86.1811	56.765
2015	7	20	8	24	8	0.3	3.9	0.7	99.2	86.1811	56.2295
2015	7	20	8	34	8	0.3	3.9	0.71	95.3	86.1811	57.8361
2015	7	20	8	44	8	0.3	3.9	0.71	98.3	86.1811	57.0328
2015	7	20	8	54	8	0.3	3.9	0.69	98.2	86.1811	55.9617
2015	7	20	9	4	8	0.3	3.9	0.71	96.7	86.1811	57.3005
2015	7	20	9	14	8	0.3	3.9	0.69	96	86.1811	56.2295
2015	7	20	9	24	8	0.3	3.9	0.71	97.5	86.1811	57.3005
2015	7	20	9	34	8	0.3	3.9	0.72	99.5	86.1155	57.7904
2015	7	20	9	44	8	0.3	3.9	0.72	100.3	86.1155	57.5228
2015	7	20	9	54	8	0.3	3.9	0.74	99.2	86.1155	59.3956
2015	7	20	10	4	8	0.3	3.9	0.68	97	86.1155	54.8473
2015	7	20	10	14	8	0.3	3.9	0.7	98.4	86.1155	56.4526
2015	7	20	10	24	8	0.3	3.9	0.73	98	86.1811	59.1748
2015	7	20	10	34	8	0.3	3.9	0.7	97.2	86.1155	56.9877
2015	7	20	10	44	8	0.3	3.9	0.74	98.7	86.1155	59.6632
2015	7	20	10	54	8	0.3	3.9	0.73	100.1	86.1155	58.3254
2015	7	20	11	4	8	0.3	3.9	0.69	102.9	86.1155	54.8473
2015	7	20	11	14	8	0.3	3.9	0.69	99.9	86.1155	55.1148
2015	7	20	11	24	8	0.3	3.9	0.72	99.5	86.1155	57.5227
2015	7	20	11	34	8	0.3	3.9	0.71	99.9	86.1155	56.9877
2015	7	20	11	44	8	0.3	3.9	0.71	100.8	86.1155	57.2551
2015	7	20	11	54	8	0.3	3.9	0.72	98.7	86.1155	57.7902
2015	7	20	12	4	8	0.3	3.9	0.72	99.5	86.1155	57.5226
2015	7	20	12	14	8	0.3	3.9	0.68	100.3	86.1155	54.3121
2015	7	20	12	24	8	0.3	3.9	0.69	99	86.1155	55.9173
2015	7	20	12	34	8	0.3	3.9	0.7	101.9	86.1155	55.6498
2015	7	20	12	44	8	0.3	3.9	0.71	98.8	86.1155	57.2551
2015	7	20	12	54	8	0.3	3.9	0.71	100.4	86.1155	56.72
2015	7	20	13	4	8	0.3	3.9	0.72	98.1	86.1155	58.3253
2015	7	20	13	14	8	0.3	3.9	0.67	101	86.1155	53.7769
2015	7	20	13	24	8	0.3	3.9	0.71	101.7	86.1155	56.72
2015	7	20	13	34	8	0.3	3.9	0.71	96.6	86.0499	57.4771
2015	7	20	13	44	8	0.3	3.9	0.71	101.7	86.0499	56.9425
2015	7	20	13	54	8	0.3	3.9	0.71	101.8	86.0499	56.4078

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	20	14	4	8	0.3	3.9	0.7	102.5	86.0499	55.6058
2015	7	20	14	14	8	0.3	3.9	0.72	101.4	86.0499	57.2098
2015	7	20	14	24	8	0.3	3.9	0.72	101.4	86.0499	57.2098
2015	7	20	14	34	8	0.3	3.9	0.71	101.3	86.0499	56.4078
2015	7	20	14	44	8	0.3	3.9	0.7	98.7	86.0499	56.1405
2015	7	20	14	54	8	0.3	3.9	0.73	100.6	86.0499	58.8138
2015	7	20	15	4	8	0.3	3.9	0.72	100.4	86.0499	58.0118
2015	7	20	15	14	8	0.3	3.9	0.69	99.9	86.0499	55.3385
2015	7	20	15	24	8	0.3	3.9	0.72	102.1	85.9843	57.4317
2015	7	20	15	34	8	0.3	3.9	0.7	99.8	86.0499	55.8731
2015	7	20	15	44	8	0.3	3.9	0.7	98.1	86.0499	56.6751
2015	7	20	15	54	8	0.3	3.9	0.71	94.7	85.9843	57.9659
2015	7	20	16	4	8	0.3	3.9	0.72	95.5	85.9843	57.9659
2015	7	20	16	14	8	0.3	3.9	0.67	97	85.9843	54.4933
2015	7	20	16	24	8	0.3	3.9	0.71	100.2	85.9843	56.6303
2015	7	20	16	34	8	0.3	3.9	0.71	99	85.9843	57.4317
2015	7	20	16	44	8	0.3	3.9	0.72	97.9	85.9843	57.966
2015	7	20	16	54	8	0.3	3.9	0.7	98.4	85.9843	56.3632
2015	7	20	17	4	8	0.3	3.9	0.68	98	85.9843	55.0276
2015	7	20	17	14	8	0.3	3.9	0.73	96.5	85.9843	59.0344
2015	7	20	17	24	8	0.3	3.9	0.7	98.6	85.9843	56.3632
2015	7	20	17	34	8	0.3	3.9	0.7	98.7	85.9843	56.0961
2015	7	20	17	44	8	0.3	3.9	0.71	100.6	85.9843	57.1645
2015	7	20	17	54	8	0.3	3.9	0.73	99.6	85.9843	58.233
2015	7	20	18	4	8	0.3	3.9	0.71	98.5	85.9843	56.8974
2015	7	20	18	14	8	0.3	3.9	0.69	99.1	85.9843	55.2947
2015	7	20	18	24	8	0.3	3.9	0.7	96.2	85.9843	56.6303
2015	7	20	18	34	8	0.3	3.9	0.73	96.5	85.9843	58.7673
2015	7	20	18	44	8	0.3	3.9	0.7	98.3	85.9843	56.6303
2015	7	20	18	54	8	0.3	3.9	0.73	98	85.9843	59.0344
2015	7	20	19	4	8	0.3	3.9	0.68	97.5	85.9843	55.0275
2015	7	20	19	14	8	0.3	3.9	0.69	97.7	85.9843	55.2946
2015	7	20	19	24	8	0.3	3.9	0.74	96.4	85.9843	59.5686
2015	7	20	19	34	8	0.3	3.9	0.73	96.7	85.9843	59.0344
2015	7	20	19	44	8	0.3	3.9	0.69	94.9	85.9843	56.3631
2015	7	20	19	54	8	0.3	3.9	0.73	96.9	85.9843	59.3015
2015	7	20	20	4	8	0.3	3.9	0.71	97.5	85.9843	57.1645
2015	7	20	20	14	8	0.3	3.9	0.72	99.2	86.0499	57.7444
2015	7	20	20	24	8	0.3	3.9	0.69	99.9	86.0499	55.0711
2015	7	20	20	34	8	0.3	3.9	0.69	96.8	86.0499	55.873
2015	7	20	20	44	8	0.3	3.9	0.71	98.2	86.0499	57.2097
2015	7	20	20	54	8	0.3	3.9	0.7	95.7	86.0499	56.4077
2015	7	20	21	4	8	0.3	3.9	0.72	96.6	86.0499	58.0117
2015	7	20	21	14	8	0.3	3.9	0.68	99.4	86.0499	55.071
2015	7	20	21	24	8	0.3	3.9	0.69	95.5	86.0499	55.873
2015	7	20	21	34	8	0.3	3.9	0.72	97.9	86.0499	58.0117
2015	7	20	21	44	8	0.3	3.9	0.73	96.7	86.0499	59.081

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	20	21	54	8	0.3	3.9	0.67	97	86.0499	54.5363
2015	7	20	22	4	8	0.3	3.9	0.7	97.6	86.1155	56.4523
2015	7	20	22	14	8	0.3	3.9	0.7	95.9	86.1155	56.9874
2015	7	20	22	24	8	0.3	3.9	0.69	98.5	86.1155	55.6497
2015	7	20	22	34	8	0.3	3.9	0.67	96.7	86.1155	54.3119
2015	7	20	22	44	8	0.3	3.9	0.7	95.6	86.1155	56.9874
2015	7	20	22	54	8	0.3	3.9	0.73	96.7	86.1155	59.1278
2015	7	20	23	4	8	0.3	3.9	0.72	98.1	86.1155	58.3251
2015	7	20	23	14	8	0.3	3.9	0.71	97.4	86.1155	57.79
2015	7	20	23	24	8	0.3	3.9	0.68	97.4	86.1155	55.3821
2015	7	20	23	34	8	0.3	3.9	0.7	97.6	86.1155	56.4523
2015	7	20	23	44	8	0.3	3.9	0.7	96.2	86.1155	56.4523
2015	7	20	23	54	8	0.3	3.9	0.66	98.3	86.1155	53.5093
2015	7	21	0	4	8	0.3	3.9	0.72	97.3	86.1155	58.5927
2015	7	21	0	14	8	0.3	3.9	0.68	94.4	86.1155	55.3821
2015	7	21	0	24	8	0.3	3.9	0.69	99.6	86.1155	55.3821
2015	7	21	0	34	8	0.3	3.9	0.71	98.3	86.1155	56.9874
2015	7	21	0	44	8	0.3	3.9	0.7	95.9	86.1155	56.9874
2015	7	21	0	54	8	0.3	3.9	0.72	96.8	86.1155	58.5927
2015	7	21	1	4	8	0.3	3.9	0.69	96	86.1155	55.6497
2015	7	21	1	14	8	0.3	3.9	0.71	95.8	86.1155	57.5225
2015	7	21	1	24	8	0.3	3.9	0.69	96.5	86.1811	56.2292
2015	7	21	1	34	8	0.3	3.9	0.7	97.5	86.1811	57.0325
2015	7	21	1	44	8	0.3	3.9	0.7	95.9	86.1811	56.7648
2015	7	21	1	54	8	0.3	3.9	0.71	95.8	86.1155	57.5225
2015	7	21	2	4	8	0.3	3.9	0.69	94.3	86.1811	56.497
2015	7	21	2	14	8	0.3	3.9	0.71	97.5	86.1811	57.3003
2015	7	21	2	24	8	0.3	3.9	0.69	98.4	86.1811	55.9615
2015	7	21	2	34	8	0.3	3.9	0.67	96.4	86.1811	54.6227
2015	7	21	2	44	8	0.3	3.9	0.69	96.8	86.1811	56.2293
2015	7	21	2	54	8	0.3	3.9	0.7	96.7	86.1811	56.7648
2015	7	21	3	4	8	0.3	3.9	0.69	94.9	86.1811	56.497
2015	7	21	3	14	8	0.3	3.9	0.68	95.5	86.1811	55.426
2015	7	21	3	24	8	0.3	3.9	0.7	97.2	86.1811	57.0326
2015	7	21	3	34	8	0.3	3.9	0.7	98.8	86.1811	56.7648
2015	7	21	3	44	8	0.3	3.9	0.66	96	86.1811	53.8195
2015	7	21	3	54	8	0.3	3.9	0.72	97.1	86.1811	58.1036
2015	7	21	4	4	8	0.3	3.9	0.7	96.7	86.1811	56.7648
2015	7	21	4	14	8	0.3	3.9	0.71	96.1	86.1811	57.8359
2015	7	21	4	24	8	0.3	3.9	0.7	97.6	86.1811	56.4971
2015	7	21	4	34	8	0.3	3.9	0.7	93.5	86.1811	56.7649
2015	7	21	4	44	8	0.3	3.9	0.7	98.6	86.1811	56.4971
2015	7	21	4	54	8	0.3	3.9	0.72	97.6	86.1811	58.3714
2015	7	21	5	4	8	0.3	3.9	0.7	96.8	86.1811	56.4971
2015	7	21	5	14	8	0.3	3.9	0.72	98.4	86.1811	58.3715
2015	7	21	5	24	8	0.3	3.9	0.72	96.6	86.1811	58.1037
2015	7	21	5	34	8	0.3	3.9	0.69	93	86.1811	55.9616

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	21	5	44	8	0.3	3.9	0.71	98	86.1811	57.3004
2015	7	21	5	54	8	0.3	3.9	0.72	97.3	86.1811	58.6393
2015	7	21	6	4	8	0.3	3.9	0.71	94.2	86.1811	58.1038
2015	7	21	6	14	8	0.3	3.9	0.67	95.9	86.1811	54.6229
2015	7	21	6	24	8	0.3	3.9	0.72	97.9	86.1811	58.1038
2015	7	21	6	34	8	0.3	3.9	0.7	98.1	86.1811	56.765
2015	7	21	6	44	8	0.3	3.9	0.71	97.2	86.1811	57.5683
2015	7	21	6	54	8	0.3	3.9	0.68	97	86.1811	54.8907
2015	7	21	7	4	8	0.3	3.9	0.73	97.5	86.2467	58.9536
2015	7	21	7	14	8	0.3	3.9	0.72	97.9	86.1811	58.1038
2015	7	21	7	24	8	0.3	3.9	0.68	98.6	86.2467	54.9341
2015	7	21	7	34	8	0.3	3.9	0.69	95.2	86.2467	56.2739
2015	7	21	7	44	8	0.3	3.9	0.71	96.3	86.2467	57.8817
2015	7	21	7	54	8	0.3	3.9	0.67	95.6	86.2467	54.6661
2015	7	21	8	4	8	0.3	3.9	0.71	95.3	86.2467	57.6138
2015	7	21	8	14	8	0.3	3.9	0.74	97.6	86.2467	60.0255
2015	7	21	8	24	8	0.3	3.9	0.7	96.8	86.2467	56.5419
2015	7	21	8	34	8	0.3	3.9	0.7	95.7	86.2467	56.8098
2015	7	21	8	44	8	0.3	3.9	0.7	97	86.2467	56.8098
2015	7	21	8	54	8	0.3	3.9	0.69	98.2	86.2467	55.47
2015	7	21	9	4	8	0.3	3.9	0.7	98.9	86.2467	56.5418
2015	7	21	9	14	8	0.3	3.9	0.71	98.3	86.2467	57.0778
2015	7	21	9	24	8	0.3	3.9	0.7	98.1	86.2467	56.5418
2015	7	21	9	34	8	0.3	3.9	0.69	97.7	86.2467	55.4699
2015	7	21	9	44	8	0.3	3.9	0.74	97.9	86.2467	60.0254
2015	7	21	9	54	8	0.3	3.9	0.75	101.1	86.2467	60.2933
2015	7	21	10	4	8	0.3	3.9	0.72	99.4	86.2467	58.1496
2015	7	21	10	14	8	0.3	3.9	0.74	100.3	86.2467	59.2214
2015	7	21	10	24	8	0.3	3.9	0.71	100.2	86.2467	56.8097
2015	7	21	10	34	8	0.3	3.9	0.7	101	86.3123	56.3182
2015	7	21	10	44	8	0.3	3.9	0.71	97.8	86.2467	57.0776
2015	7	21	10	54	8	0.3	3.9	0.7	99.7	86.2467	56.2737
2015	7	21	11	4	8	0.3	3.9	0.73	99.6	86.2467	58.4175
2015	7	21	11	14	8	0.3	3.9	0.73	101.2	86.2467	58.1495
2015	7	21	11	24	8	0.3	3.9	0.7	99.1	86.2467	56.8096
2015	7	21	11	34	8	0.3	3.9	0.71	99.6	86.2467	56.8096
2015	7	21	11	44	8	0.3	3.9	0.74	100	86.2467	59.4893
2015	7	21	11	54	8	0.3	3.9	0.72	98.6	86.2467	58.1494
2015	7	21	12	4	8	0.3	3.9	0.72	98.4	86.2467	58.1494
2015	7	21	12	14	8	0.3	3.9	0.71	100.9	86.2467	56.8096
2015	7	21	12	24	8	0.3	3.9	0.71	100.2	86.2467	56.8095
2015	7	21	12	34	8	0.3	3.9	0.69	99.8	86.2467	55.7377
2015	7	21	12	44	8	0.3	3.9	0.7	103.3	86.2467	55.7376
2015	7	21	12	54	8	0.3	3.9	0.72	102	86.2467	57.8814
2015	7	21	13	4	8	0.3	3.9	0.69	102.4	86.1811	54.6226
2015	7	21	13	14	8	0.3	3.9	0.71	100.1	86.2467	57.3454
2015	7	21	13	24	8	0.3	3.9	0.7	98.3	86.2467	56.8095

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	21	13	34	8	0.3	3.9	0.72	99.8	86.1811	57.5679
2015	7	21	13	44	8	0.3	3.9	0.72	100.5	86.1811	57.8356
2015	7	21	13	54	8	0.3	3.9	0.72	102.1	86.1811	57.5679
2015	7	21	14	4	8	0.3	3.9	0.71	100.9	86.1811	56.7646
2015	7	21	14	14	8	0.3	3.9	0.7	98.9	86.1811	56.4968
2015	7	21	14	24	8	0.3	3.9	0.7	100.5	86.1811	56.2291
2015	7	21	14	34	8	0.3	3.9	0.73	98.8	86.1811	58.9066
2015	7	21	14	44	8	0.3	3.9	0.7	99.7	86.1811	56.4968
2015	7	21	14	54	8	0.3	3.9	0.69	100.6	86.1811	55.6936
2015	7	21	15	4	8	0.3	3.9	0.7	98.3	86.1811	56.7646
2015	7	21	15	14	8	0.3	3.9	0.71	101	86.1811	56.4968
2015	7	21	15	24	8	0.3	3.9	0.72	99.4	86.1811	58.1034
2015	7	21	15	34	8	0.3	3.9	0.7	99.1	86.1811	56.7646
2015	7	21	15	44	8	0.3	3.9	0.72	99.4	86.1811	58.3711
2015	7	21	15	54	8	0.3	3.9	0.73	101.9	86.1155	58.325
2015	7	21	16	4	8	0.3	3.9	0.73	99.3	86.1155	59.1277
2015	7	21	16	14	8	0.3	3.9	0.71	95.8	86.1155	57.5224
2015	7	21	16	24	8	0.3	3.9	0.73	101.6	86.1155	58.5926
2015	7	21	16	34	8	0.3	3.9	0.71	101.5	86.1811	56.7647
2015	7	21	16	44	8	0.3	3.9	0.71	99.3	86.1155	57.2549
2015	7	21	16	54	8	0.3	3.9	0.72	98.1	86.1155	58.0575
2015	7	21	17	4	8	0.3	3.9	0.73	100.7	86.1811	58.3712
2015	7	21	17	14	8	0.3	3.9	0.72	98.9	86.1811	58.3712
2015	7	21	17	24	8	0.3	3.9	0.71	96.9	86.1811	57.3002
2015	7	21	17	34	8	0.3	3.9	0.7	98.4	86.1811	56.2291
2015	7	21	17	44	8	0.3	3.9	0.7	97.6	86.1811	56.4969
2015	7	21	17	54	8	0.3	3.9	0.72	96.3	86.1811	58.1034
2015	7	21	18	4	8	0.3	3.9	0.71	95.6	86.1811	57.3001
2015	7	21	18	14	8	0.3	3.9	0.68	97.7	86.1811	55.1581
2015	7	21	18	24	8	0.3	3.9	0.7	95.9	86.1811	57.0324
2015	7	21	18	34	8	0.3	3.9	0.72	99.8	86.1811	57.5679
2015	7	21	18	44	8	0.3	3.9	0.7	96.7	86.1811	57.0324
2015	7	21	18	54	8	0.3	3.9	0.71	98.5	86.1811	57.5679
2015	7	21	19	4	8	0.3	3.9	0.71	96.7	86.1811	57.3001
2015	7	21	19	14	8	0.3	3.9	0.72	94.2	86.1811	58.3711
2015	7	21	19	24	8	0.3	3.9	0.69	96	86.2467	56.2735
2015	7	21	19	34	8	0.3	3.9	0.72	98.1	86.1811	58.1034
2015	7	21	19	44	8	0.3	3.9	0.72	97.1	86.1811	58.1034
2015	7	21	19	54	8	0.3	3.9	0.7	97	86.2467	57.0774
2015	7	21	20	4	8	0.3	3.9	0.72	95.8	86.2467	58.4172
2015	7	21	20	14	8	0.3	3.9	0.67	91.4	86.2467	54.9336
2015	7	21	20	24	8	0.3	3.9	0.7	95.7	86.2467	56.8094
2015	7	21	20	34	8	0.3	3.9	0.7	97	86.2467	56.5414
2015	7	21	20	44	8	0.3	3.9	0.69	94.4	86.2467	56.2734
2015	7	21	20	54	8	0.3	3.9	0.72	97.1	86.2467	58.1492
2015	7	21	21	4	8	0.3	3.9	0.68	97.2	86.2467	55.2016
2015	7	21	21	14	8	0.3	3.9	0.71	96.9	86.2467	57.8812

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	21	21	24	8	0.3	3.9	0.72	97.9	86.2467	57.8812
2015	7	21	21	34	8	0.3	3.9	0.68	94.4	86.2467	55.7375
2015	7	21	21	44	8	0.3	3.9	0.7	97	86.2467	57.0773
2015	7	21	21	54	8	0.3	3.9	0.69	97.1	86.3123	56.0496
2015	7	21	22	4	8	0.3	3.9	0.72	98.1	86.3123	58.1951
2015	7	21	22	14	8	0.3	3.9	0.69	97.4	86.3123	55.7814
2015	7	21	22	24	8	0.3	3.9	0.69	97.1	86.3123	55.7814
2015	7	21	22	34	8	0.3	3.9	0.69	96.3	86.3123	56.0496
2015	7	21	22	44	8	0.3	3.9	0.7	96.8	86.3123	56.586
2015	7	21	22	54	8	0.3	3.9	0.71	95	86.3123	58.195
2015	7	21	23	4	8	0.3	3.9	0.71	96.7	86.3123	57.3905
2015	7	21	23	14	8	0.3	3.9	0.71	97.7	86.3123	57.3905
2015	7	21	23	24	8	0.3	3.9	0.73	96.9	86.3123	59.5359
2015	7	21	23	34	8	0.3	3.9	0.72	96.5	86.378	58.5093
2015	7	21	23	44	8	0.3	3.9	0.71	96.9	86.378	57.9726
2015	7	21	23	54	8	0.3	3.9	0.71	96.6	86.378	57.9726
2015	7	22	0	4	8	0.3	3.9	0.7	94	86.378	57.1674
2015	7	22	0	14	8	0.3	3.9	0.7	98.4	86.378	56.3622
2015	7	22	0	24	8	0.3	3.9	0.71	97.5	86.378	57.4358
2015	7	22	0	34	8	0.3	3.9	0.69	95.8	86.378	55.8254
2015	7	22	0	44	8	0.3	3.9	0.68	97.4	86.378	55.5571
2015	7	22	0	54	8	0.3	3.9	0.69	94.9	86.378	56.6306
2015	7	22	1	4	8	0.3	3.9	0.71	97.2	86.378	57.7042
2015	7	22	1	14	8	0.3	3.9	0.68	98.1	86.378	55.0203
2015	7	22	1	24	8	0.3	3.9	0.67	97	86.378	54.7519
2015	7	22	1	34	8	0.3	3.9	0.72	98.6	86.4436	58.5555
2015	7	22	1	44	8	0.3	3.9	0.69	97.7	86.4436	55.6009
2015	7	22	1	54	8	0.3	3.9	0.69	98.2	86.4436	55.6009
2015	7	22	2	4	8	0.3	3.9	0.69	95.7	86.4436	56.4067
2015	7	22	2	14	8	0.3	3.9	0.72	99.8	86.4436	57.7498
2015	7	22	2	24	8	0.3	3.9	0.67	97	86.4436	54.7951
2015	7	22	2	34	8	0.3	3.9	0.71	97.4	86.4436	58.0184
2015	7	22	2	44	8	0.3	3.9	0.73	96.7	86.4436	59.3614
2015	7	22	2	54	8	0.3	3.9	0.69	94.9	86.4436	56.6754
2015	7	22	3	4	8	0.3	3.9	0.69	96.5	86.4436	56.4068
2015	7	22	3	14	8	0.3	3.9	0.71	95.6	86.4436	57.4812
2015	7	22	3	24	8	0.3	3.9	0.7	96.8	86.4436	56.6754
2015	7	22	3	34	8	0.3	3.9	0.71	95.6	86.5092	57.5265
2015	7	22	3	44	8	0.3	3.9	0.74	97.7	86.5092	59.9459
2015	7	22	3	54	8	0.3	3.9	0.71	94.5	86.5092	58.333
2015	7	22	4	4	8	0.3	3.9	0.65	94.1	86.5748	52.9984
2015	7	22	4	14	8	0.3	3.9	0.71	95.6	86.6404	57.6171
2015	7	22	4	24	8	0.3	3.9	0.68	94.4	86.6404	55.4632
2015	7	22	4	34	8	0.3	3.9	0.72	94.5	86.706	58.7402
2015	7	22	4	44	8	0.3	3.9	0.71	96.6	86.706	58.2014
2015	7	22	4	54	8	0.3	3.9	0.72	98.1	86.706	58.7403
2015	7	22	5	4	8	0.3	3.9	0.7	95.7	86.706	57.1236

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	22	5	14	8	0.3	3.9	0.73	98.1	86.7717	59.0561
2015	7	22	5	24	8	0.3	3.9	0.68	97.2	86.7717	55.5505
2015	7	22	5	34	8	0.3	3.9	0.74	96.1	86.7717	60.1347
2015	7	22	5	44	8	0.3	3.9	0.72	96.6	86.7717	58.5168
2015	7	22	5	54	8	0.3	3.9	0.69	95.7	86.7717	56.3595
2015	7	22	6	4	8	0.3	3.9	0.67	95.9	86.7717	55.0112
2015	7	22	6	14	8	0.3	3.9	0.73	96.2	86.7717	59.3258
2015	7	22	6	24	8	0.3	3.9	0.7	96	86.7717	56.8989
2015	7	22	6	34	8	0.3	3.9	0.67	97.7	86.7717	54.2022
2015	7	22	6	44	8	0.3	3.9	0.7	95.7	86.8373	57.2134
2015	7	22	6	54	8	0.3	3.9	0.7	100	86.8373	56.6737
2015	7	22	7	4	8	0.3	3.9	0.69	96.3	86.8373	56.4038
2015	7	22	7	14	8	0.3	3.9	0.71	99	86.8373	58.0231
2015	7	22	7	24	8	0.3	3.9	0.71	96.1	86.8373	57.7532
2015	7	22	7	34	8	0.3	3.9	0.73	96.4	86.8373	59.9122
2015	7	22	7	44	8	0.3	3.9	0.72	96.3	86.8373	58.5628
2015	7	22	7	54	8	0.3	3.9	0.7	95.9	86.8373	57.4833
2015	7	22	8	4	8	0.3	3.9	0.7	96.7	86.8373	57.2134
2015	7	22	8	14	8	0.3	3.9	0.68	97.5	86.8373	55.3243
2015	7	22	8	24	8	0.3	3.9	0.72	96.8	86.8373	58.5628
2015	7	22	8	34	8	0.3	3.9	0.71	97.2	86.8373	58.0231
2015	7	22	8	44	8	0.3	3.9	0.72	99.2	86.8373	58.5628
2015	7	22	8	54	8	0.3	3.9	0.69	96.3	86.8373	56.4038
2015	7	22	9	4	8	0.3	3.9	0.68	97.7	86.8373	55.5942
2015	7	22	9	14	8	0.3	3.9	0.74	96.8	86.8373	60.7218
2015	7	22	9	24	8	0.3	3.9	0.71	99	86.8373	58.023
2015	7	22	9	34	8	0.3	3.9	0.72	98.4	86.8373	58.5628
2015	7	22	9	44	8	0.3	3.9	0.73	99.3	86.8373	59.6423
2015	7	22	9	54	8	0.3	3.9	0.75	99	86.8373	61.2615
2015	7	22	10	4	8	0.3	3.9	0.71	101.7	86.8373	57.4832
2015	7	22	10	14	8	0.3	3.9	0.71	100.9	86.8373	57.2134
2015	7	22	10	24	8	0.3	3.9	0.72	101	86.8373	58.2928
2015	7	22	10	34	8	0.3	3.9	0.73	100.1	86.8373	59.3723
2015	7	22	10	44	8	0.3	3.9	0.74	100.5	86.8373	59.6422
2015	7	22	10	54	8	0.3	3.9	0.71	100.7	86.8373	57.2133
2015	7	22	11	4	8	0.3	3.9	0.74	99.8	86.8373	59.6422
2015	7	22	11	14	8	0.3	3.9	0.7	101.3	86.8373	56.6735
2015	7	22	11	24	8	0.3	3.9	0.7	97	86.8373	57.4832
2015	7	22	11	34	8	0.3	3.9	0.71	101.5	86.7717	56.8987
2015	7	22	11	44	8	0.3	3.9	0.71	100.4	86.7717	57.4381
2015	7	22	11	54	8	0.3	3.9	0.71	102.3	86.7717	56.8987
2015	7	22	12	4	8	0.3	3.9	0.72	96.1	86.7717	58.5167
2015	7	22	12	14	8	0.3	3.9	0.7	100.2	86.7717	56.8987
2015	7	22	12	24	8	0.3	3.9	0.71	102.3	86.7717	56.8987
2015	7	22	12	34	8	0.3	3.9	0.72	98.7	86.7717	58.247
2015	7	22	12	44	8	0.3	3.9	0.73	95.9	86.7717	59.865
2015	7	22	12	54	8	0.3	3.9	0.66	99.1	86.706	53.8901

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	22	13	4	8	0.3	3.9	0.72	100.7	86.706	58.4707
2015	7	22	13	14	8	0.3	3.9	0.71	98.8	86.706	57.6624
2015	7	22	13	24	8	0.3	3.9	0.71	97.8	86.706	57.3929
2015	7	22	13	34	8	0.3	3.9	0.71	101.2	86.706	57.3929
2015	7	22	13	44	8	0.3	3.9	0.67	102.7	86.706	53.6206
2015	7	22	13	54	8	0.3	3.9	0.73	97	86.706	59.279
2015	7	22	14	4	8	0.3	3.9	0.71	100.2	86.706	57.1235
2015	7	22	14	14	8	0.3	3.9	0.69	96.8	86.706	56.5845
2015	7	22	14	24	8	0.3	3.9	0.69	98.5	86.6404	56.0016
2015	7	22	14	34	8	0.3	3.9	0.66	98.6	86.706	53.6206
2015	7	22	14	44	8	0.3	3.9	0.67	95	86.5748	54.8815
2015	7	22	14	54	8	0.3	3.9	0.71	102.4	86.6404	56.5401
2015	7	22	15	4	8	0.3	3.9	0.69	96	86.6404	56.5401
2015	7	22	15	14	8	0.3	3.9	0.7	99.2	86.6404	56.5401
2015	7	22	15	24	8	0.3	3.9	0.69	99.3	86.6404	56.0016
2015	7	22	15	34	8	0.3	3.9	0.73	98	86.6404	59.5018
2015	7	22	15	44	8	0.3	3.9	0.72	101.4	86.5748	57.5718
2015	7	22	15	54	8	0.3	3.9	0.69	101.3	86.5092	55.376
2015	7	22	16	4	8	0.3	3.9	0.68	97.2	86.6404	55.4632
2015	7	22	16	14	8	0.3	3.9	0.68	97.7	86.5748	55.4196
2015	7	22	16	24	8	0.3	3.9	0.7	98.3	86.5748	57.0338
2015	7	22	16	34	8	0.3	3.9	0.7	98.3	86.5748	57.0338
2015	7	22	16	44	8	0.3	3.9	0.72	96.3	86.5748	58.648
2015	7	22	16	54	8	0.3	3.9	0.72	99.1	86.5748	58.648
2015	7	22	17	4	8	0.3	3.9	0.72	95.2	86.5748	58.917
2015	7	22	17	14	8	0.3	3.9	0.71	96.1	86.5092	57.5266
2015	7	22	17	24	8	0.3	3.9	0.71	95.6	86.5748	57.8409
2015	7	22	17	34	8	0.3	3.9	0.72	97.4	86.5748	58.3789
2015	7	22	17	44	8	0.3	3.9	0.71	97.8	86.5092	57.2578
2015	7	22	17	54	8	0.3	3.9	0.71	94.3	86.5748	57.8409
2015	7	22	18	4	8	0.3	3.9	0.71	101.7	86.5092	57.2578
2015	7	22	18	14	8	0.3	3.9	0.72	99.7	86.5748	58.3789
2015	7	22	18	24	8	0.3	3.9	0.72	98.4	86.5748	58.3789
2015	7	22	18	34	8	0.3	3.9	0.69	95.7	86.5092	56.4513
2015	7	22	18	44	8	0.3	3.9	0.71	98.2	86.5748	57.8409
2015	7	22	18	54	8	0.3	3.9	0.72	97.6	86.5092	58.6018
2015	7	22	19	4	8	0.3	3.9	0.72	98.4	86.5092	58.6018
2015	7	22	19	14	8	0.3	3.9	0.72	99.4	86.5748	58.6479
2015	7	22	19	24	8	0.3	3.9	0.71	95.3	86.5092	57.5265
2015	7	22	19	34	8	0.3	3.9	0.71	98.2	86.5748	57.8408
2015	7	22	19	44	8	0.3	3.9	0.74	96.1	86.5748	59.993
2015	7	22	19	54	8	0.3	3.9	0.74	99.9	86.4436	59.8987
2015	7	22	20	4	8	0.3	3.9	0.72	100.3	86.5092	57.7953
2015	7	22	20	14	8	0.3	3.9	0.7	97	86.5748	57.3027
2015	7	22	20	24	8	0.3	3.9	0.7	99.2	86.5092	56.4512
2015	7	22	20	34	8	0.3	3.9	0.7	97	86.5748	56.7647
2015	7	22	20	44	8	0.3	3.9	0.7	98.4	86.5748	56.7647

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	22	20	54	8	0.3	3.9	0.72	97.1	86.5748	58.3788
2015	7	22	21	4	8	0.3	3.9	0.7	101	86.5092	56.4512
2015	7	22	21	14	8	0.3	3.9	0.71	94.8	86.5748	58.1098
2015	7	22	21	24	8	0.3	3.9	0.73	98	86.5092	59.1393
2015	7	22	21	34	8	0.3	3.9	0.7	96.8	86.5092	56.72
2015	7	22	21	44	8	0.3	3.9	0.7	97	86.5092	57.2576
2015	7	22	21	54	8	0.3	3.9	0.69	98.5	86.5748	55.9575
2015	7	22	22	4	8	0.3	3.9	0.71	99.6	86.5748	57.3026
2015	7	22	22	14	8	0.3	3.9	0.7	93.2	86.5748	57.0336
2015	7	22	22	24	8	0.3	3.9	0.7	96.7	86.6404	57.0785
2015	7	22	22	34	8	0.3	3.9	0.71	95.3	86.6404	58.1554
2015	7	22	22	44	8	0.3	3.9	0.71	97.7	86.6404	57.6169
2015	7	22	22	54	8	0.3	3.9	0.7	97.9	86.706	56.5844
2015	7	22	23	4	8	0.3	3.9	0.72	98.1	86.7717	58.7861
2015	7	22	23	14	8	0.3	3.9	0.71	95.6	86.7717	58.2468
2015	7	22	23	24	8	0.3	3.9	0.72	96.5	86.7717	59.0558
2015	7	22	23	34	8	0.3	3.9	0.7	97.8	86.7717	57.1682
2015	7	22	23	44	8	0.3	3.9	0.69	93.8	86.7717	56.6288
2015	7	22	23	54	8	0.3	3.9	0.7	98.4	86.7717	56.6288
2015	7	23	0	4	8	0.3	3.9	0.69	95.2	86.7717	56.6288
2015	7	23	0	14	8	0.3	3.9	0.69	96.8	86.8373	56.4034
2015	7	23	0	24	8	0.3	3.9	0.71	97.2	86.8373	57.7528
2015	7	23	0	34	8	0.3	3.9	0.71	96.7	86.8373	57.7528
2015	7	23	0	44	8	0.3	3.9	0.71	95.8	86.8373	58.0226
2015	7	23	0	54	8	0.3	3.9	0.72	97.9	86.8373	58.2925
2015	7	23	1	4	8	0.3	3.9	0.7	96.2	86.8373	56.9432
2015	7	23	1	14	8	0.3	3.9	0.71	96.6	86.8373	58.2925
2015	7	23	1	24	8	0.3	3.9	0.66	96	86.8373	53.7047
2015	7	23	1	34	8	0.3	3.9	0.76	99	86.8373	61.531
2015	7	23	1	44	8	0.3	3.9	0.67	96.2	86.8373	54.7842
2015	7	23	1	54	8	0.3	3.9	0.71	96.1	86.8373	57.7528
2015	7	23	2	4	8	0.3	3.9	0.69	96.8	86.9029	56.4477
2015	7	23	2	14	8	0.3	3.9	0.72	95.2	86.9029	58.8784
2015	7	23	2	24	8	0.3	3.9	0.69	95.7	86.9029	56.7178
2015	7	23	2	34	8	0.3	3.9	0.72	96.8	86.9029	58.8785
2015	7	23	2	44	8	0.3	3.9	0.73	97	86.9029	59.4186
2015	7	23	2	54	8	0.3	3.9	0.71	97.4	86.9029	58.3383
2015	7	23	3	4	8	0.3	3.9	0.69	96.9	86.9029	56.1776
2015	7	23	3	14	8	0.3	3.9	0.73	96.5	86.9029	59.6887
2015	7	23	3	24	8	0.3	3.9	0.74	95.9	86.9029	60.499
2015	7	23	3	34	8	0.3	3.9	0.72	96.8	86.9029	59.1486
2015	7	23	3	44	8	0.3	3.9	0.69	95.2	86.9029	56.1777
2015	7	23	3	54	8	0.3	3.9	0.68	95.8	86.9029	55.9076
2015	7	23	4	4	8	0.3	3.9	0.73	96.5	86.9029	59.6888
2015	7	23	4	14	8	0.3	3.9	0.7	96.4	86.9029	57.5281
2015	7	23	4	24	8	0.3	3.9	0.7	96.7	86.9029	57.5282
2015	7	23	4	34	8	0.3	3.9	0.73	98.1	86.9029	59.1487

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	23	4	44	8	0.3	3.9	0.72	96.6	86.9029	58.6085
2015	7	23	4	54	8	0.3	3.9	0.7	97.6	86.9029	56.988
2015	7	23	5	4	8	0.3	3.9	0.72	94.5	86.9029	58.8786
2015	7	23	5	14	8	0.3	3.9	0.69	96.3	86.9029	56.4479
2015	7	23	5	24	8	0.3	3.9	0.71	96.1	86.9685	58.3842
2015	7	23	5	34	8	0.3	3.9	0.7	95.4	86.9029	57.5282
2015	7	23	5	44	8	0.3	3.9	0.69	97.3	86.9685	56.7624
2015	7	23	5	54	8	0.3	3.9	0.71	96.1	86.9029	57.7983
2015	7	23	6	4	8	0.3	3.9	0.71	96.6	86.9029	58.0684
2015	7	23	6	14	8	0.3	3.9	0.69	96	86.9685	56.7625
2015	7	23	6	24	8	0.3	3.9	0.7	94.6	86.9685	57.5734
2015	7	23	6	34	8	0.3	3.9	0.73	97.4	86.9685	60.0061
2015	7	23	6	44	8	0.3	3.9	0.68	98	86.9685	55.6813
2015	7	23	6	54	8	0.3	3.9	0.69	95.2	86.9029	56.1779
2015	7	23	7	4	8	0.3	3.9	0.71	97.2	86.9685	58.114
2015	7	23	7	14	8	0.3	3.9	0.72	99.2	86.9685	58.6546
2015	7	23	7	24	8	0.3	3.9	0.68	98.6	86.9685	55.6813
2015	7	23	7	34	8	0.3	3.9	0.69	97.6	86.9685	56.4922
2015	7	23	7	44	8	0.3	3.9	0.71	97.8	86.9685	57.5734
2015	7	23	7	54	8	0.3	3.9	0.73	98	86.9685	59.7358
2015	7	23	8	4	8	0.3	3.9	0.72	96.6	86.9685	58.6546
2015	7	23	8	14	8	0.3	3.9	0.72	97.4	86.9685	58.6546
2015	7	23	8	24	8	0.3	3.9	0.72	98.1	86.9685	58.6546
2015	7	23	8	34	8	0.3	3.9	0.74	100.5	86.9685	59.7358
2015	7	23	8	44	8	0.3	3.9	0.71	96.6	86.9685	58.114
2015	7	23	8	54	8	0.3	3.9	0.75	98.8	86.9685	60.817
2015	7	23	9	4	8	0.3	3.9	0.74	99	86.9685	60.0061
2015	7	23	9	14	8	0.3	3.9	0.75	96.8	86.9685	61.6278
2015	7	23	9	24	8	0.3	3.9	0.72	100.8	86.9685	58.114
2015	7	23	9	34	8	0.3	3.9	0.72	99.4	86.9685	58.6545
2015	7	23	9	44	8	0.3	3.9	0.7	97.3	86.9685	57.3031
2015	7	23	9	54	8	0.3	3.9	0.75	101.2	86.9029	60.2291
2015	7	23	10	4	8	0.3	3.9	0.7	98.3	86.9685	57.303
2015	7	23	10	14	8	0.3	3.9	0.73	97.8	86.9029	59.1487
2015	7	23	10	24	8	0.3	3.9	0.71	98.8	86.9685	57.8436
2015	7	23	10	34	8	0.3	3.9	0.7	98.6	86.9029	57.2581
2015	7	23	10	44	8	0.3	3.9	0.73	101.6	86.9029	59.1487
2015	7	23	10	54	8	0.3	3.9	0.72	100.2	86.9029	58.6085
2015	7	23	11	4	8	0.3	3.9	0.71	98.8	86.9029	57.7983
2015	7	23	11	14	8	0.3	3.9	0.71	102	86.9029	57.2581
2015	7	23	11	24	8	0.3	3.9	0.73	99.6	86.9029	58.8786
2015	7	23	11	34	8	0.3	3.9	0.7	102.8	86.9029	55.9076
2015	7	23	11	44	8	0.3	3.9	0.72	101.4	86.9029	57.7982
2015	7	23	11	54	8	0.3	3.9	0.73	97	86.9029	59.4187
2015	7	23	12	4	8	0.3	3.9	0.74	100.5	86.9029	59.9589
2015	7	23	12	14	8	0.3	3.9	0.71	102	86.8373	57.2132
2015	7	23	12	24	8	0.3	3.9	0.71	104.4	86.8373	56.6734

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	23	12	34	8	0.3	3.9	0.71	101.7	86.8373	57.2131
2015	7	23	12	44	8	0.3	3.9	0.75	105.1	86.7717	59.8649
2015	7	23	12	54	8	0.3	3.9	0.71	100.8	86.8373	57.7529
2015	7	23	13	4	8	0.3	3.9	0.71	99.6	86.8373	57.483
2015	7	23	13	14	8	0.3	3.9	0.69	100.9	86.7717	55.8199
2015	7	23	13	24	8	0.3	3.9	0.72	99.8	86.7717	57.9772
2015	7	23	13	34	8	0.3	3.9	0.7	102.8	86.7717	55.8199
2015	7	23	13	44	8	0.3	3.9	0.7	103.1	86.7717	55.8199
2015	7	23	13	54	8	0.3	3.9	0.71	96.6	86.7717	57.9772
2015	7	23	14	4	8	0.3	3.9	0.73	98.8	86.706	59.279
2015	7	23	14	14	8	0.3	3.9	0.69	101.5	86.706	55.7761
2015	7	23	14	24	8	0.3	3.9	0.72	102.4	86.706	57.3928
2015	7	23	14	34	8	0.3	3.9	0.73	100.4	86.706	59.0095
2015	7	23	14	44	8	0.3	3.9	0.69	99.8	86.6404	56.0016
2015	7	23	14	54	8	0.3	3.9	0.67	100.4	86.706	54.4289
2015	7	23	15	4	8	0.3	3.9	0.71	98.2	86.6404	57.617
2015	7	23	15	14	8	0.3	3.9	0.7	102.8	86.6404	55.7323
2015	7	23	15	24	8	0.3	3.9	0.71	100.9	86.5748	57.3027
2015	7	23	15	34	8	0.3	3.9	0.67	102.5	86.6404	53.3092
2015	7	23	15	44	8	0.3	3.9	0.71	101.2	86.6404	57.0785
2015	7	23	15	54	8	0.3	3.9	0.7	98.4	86.5748	56.7646
2015	7	23	16	4	8	0.3	3.9	0.71	102	86.6404	56.8093
2015	7	23	16	14	8	0.3	3.9	0.69	101.3	86.6404	55.4631
2015	7	23	16	24	8	0.3	3.9	0.73	98.3	86.5748	59.1859
2015	7	23	16	34	8	0.3	3.9	0.7	99.2	86.5748	56.4956
2015	7	23	16	44	8	0.3	3.9	0.71	101.7	86.5748	57.3027
2015	7	23	16	54	8	0.3	3.9	0.68	99.4	86.5748	55.1505
2015	7	23	17	4	8	0.3	3.9	0.74	99.7	86.5748	59.993
2015	7	23	17	14	8	0.3	3.9	0.7	101.1	86.5748	56.2266
2015	7	23	17	24	8	0.3	3.9	0.74	101.3	86.5092	59.1394
2015	7	23	17	34	8	0.3	3.9	0.7	98.4	86.5092	56.4512
2015	7	23	17	44	8	0.3	3.9	0.71	98.3	86.5092	57.2577
2015	7	23	17	54	8	0.3	3.9	0.73	98.5	86.5092	59.4082
2015	7	23	18	4	8	0.3	3.9	0.69	98.7	86.5748	55.9576
2015	7	23	18	14	8	0.3	3.9	0.7	100.2	86.5092	56.7201
2015	7	23	18	24	8	0.3	3.9	0.71	96.6	86.5092	57.7953
2015	7	23	18	34	8	0.3	3.9	0.71	96.1	86.5092	58.0641
2015	7	23	18	44	8	0.3	3.9	0.7	98.7	86.5092	56.4512
2015	7	23	18	54	8	0.3	3.9	0.68	98.4	86.5092	54.8383
2015	7	23	19	4	8	0.3	3.9	0.7	96.8	86.5092	56.7201
2015	7	23	19	14	8	0.3	3.9	0.71	97.8	86.5092	57.2577
2015	7	23	19	24	8	0.3	3.9	0.72	96	86.5092	58.6018
2015	7	23	19	34	8	0.3	3.9	0.71	96.7	86.5092	57.5265
2015	7	23	19	44	8	0.3	3.9	0.7	95.4	86.5092	57.2577
2015	7	23	19	54	8	0.3	3.9	0.72	97.3	86.5092	58.6017
2015	7	23	20	4	8	0.3	3.9	0.74	98.4	86.4436	60.1672
2015	7	23	20	14	8	0.3	3.9	0.69	99.1	86.4436	55.601

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	23	20	24	8	0.3	3.9	0.7	93.8	86.5748	57.3027
2015	7	23	20	34	8	0.3	3.9	0.7	96.8	86.5748	56.7646
2015	7	23	20	44	8	0.3	3.9	0.71	94.8	86.5092	58.0641
2015	7	23	20	54	8	0.3	3.9	0.72	96.5	86.5748	58.6478
2015	7	23	21	4	8	0.3	3.9	0.69	95.5	86.5748	56.2266
2015	7	23	21	14	8	0.3	3.9	0.69	95.7	86.5748	56.2266
2015	7	23	21	24	8	0.3	3.9	0.69	94.3	86.5748	56.7646
2015	7	23	21	34	8	0.3	3.9	0.71	94.5	86.5748	57.8407
2015	7	23	21	44	8	0.3	3.9	0.7	97	86.5748	57.3027
2015	7	23	21	54	8	0.3	3.9	0.74	94	86.5748	60.8
2015	7	23	22	4	8	0.3	3.9	0.72	95.2	86.5748	58.9168
2015	7	23	22	14	8	0.3	3.9	0.69	97.1	86.5092	55.9135
2015	7	23	22	24	8	0.3	3.9	0.72	97.6	86.5092	58.6016
2015	7	23	22	34	8	0.3	3.9	0.7	95.7	86.5092	56.7199
2015	7	23	22	44	8	0.3	3.9	0.71	99.3	86.5092	57.5264
2015	7	23	22	54	8	0.3	3.9	0.68	97.2	86.5092	55.3758
2015	7	23	23	4	8	0.3	3.9	0.73	97.4	86.5092	59.6769
2015	7	23	23	14	8	0.3	3.9	0.71	97.2	86.5092	57.5263
2015	7	23	23	24	8	0.3	3.9	0.7	95.1	86.5748	57.0336
2015	7	23	23	34	8	0.3	3.9	0.7	97	86.5092	57.2575
2015	7	23	23	44	8	0.3	3.9	0.69	97.4	86.5748	55.9575
2015	7	23	23	54	8	0.3	3.9	0.74	97.4	86.5748	59.9929
2015	7	24	0	4	8	0.3	3.9	0.72	96.5	86.5748	58.9167
2015	7	24	0	14	8	0.3	3.9	0.72	96.8	86.6404	58.6939
2015	7	24	0	24	8	0.3	3.9	0.7	95.7	86.5748	56.7645
2015	7	24	0	34	8	0.3	3.9	0.73	98.3	86.6404	59.2323
2015	7	24	0	44	8	0.3	3.9	0.7	96.2	86.6404	57.3477
2015	7	24	0	54	8	0.3	3.9	0.73	97.5	86.706	59.2789
2015	7	24	1	4	8	0.3	3.9	0.73	98	86.706	59.5484
2015	7	24	1	14	8	0.3	3.9	0.71	96.9	86.706	57.6622
2015	7	24	1	24	8	0.3	3.9	0.7	95.7	86.7717	56.8985
2015	7	24	1	34	8	0.3	3.9	0.75	97.8	86.7717	60.6738
2015	7	24	1	44	8	0.3	3.9	0.72	96.3	86.7717	58.7862
2015	7	24	1	54	8	0.3	3.9	0.71	95.8	86.7717	57.9772
2015	7	24	2	4	8	0.3	3.9	0.72	97.1	86.7717	58.5165
2015	7	24	2	14	8	0.3	3.9	0.72	99.1	86.7717	58.7862
2015	7	24	2	24	8	0.3	3.9	0.72	97.9	86.7717	58.2469
2015	7	24	2	34	8	0.3	3.9	0.74	97.9	86.7717	60.1345
2015	7	24	2	44	8	0.3	3.9	0.67	97.9	86.7717	54.202
2015	7	24	2	54	8	0.3	3.9	0.68	95.8	86.8373	55.8638
2015	7	24	3	4	8	0.3	3.9	0.72	96.6	86.7717	58.5166
2015	7	24	3	14	8	0.3	3.9	0.72	98.7	86.8373	58.2927
2015	7	24	3	24	8	0.3	3.9	0.73	95.4	86.8373	60.1818
2015	7	24	3	34	8	0.3	3.9	0.68	96.1	86.8373	55.8638
2015	7	24	3	44	8	0.3	3.9	0.7	95.9	86.8373	57.2132
2015	7	24	3	54	8	0.3	3.9	0.7	93.8	86.8373	57.4831
2015	7	24	4	4	8	0.3	3.9	0.76	96.7	86.8373	62.0709

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	24	4	14	8	0.3	3.9	0.74	96.1	86.8373	60.1819
2015	7	24	4	24	8	0.3	3.9	0.7	95.9	86.8373	57.2133
2015	7	24	4	34	8	0.3	3.9	0.7	95.6	86.8373	57.4831
2015	7	24	4	44	8	0.3	3.9	0.7	97	86.8373	57.4832
2015	7	24	4	54	8	0.3	3.9	0.7	94.6	86.8373	57.2133
2015	7	24	5	4	8	0.3	3.9	0.7	95.6	86.8373	57.4832
2015	7	24	5	14	8	0.3	3.9	0.69	97.1	86.8373	56.4037
2015	7	24	5	24	8	0.3	3.9	0.69	96.8	86.8373	56.4037
2015	7	24	5	34	8	0.3	3.9	0.7	97.5	86.8373	57.2134
2015	7	24	5	44	8	0.3	3.9	0.71	97.4	86.8373	58.2929
2015	7	24	5	54	8	0.3	3.9	0.72	98.1	86.8373	58.8326
2015	7	24	6	4	8	0.3	3.9	0.68	95.3	86.8373	55.3243
2015	7	24	6	14	8	0.3	3.9	0.69	94.6	86.8373	56.6737
2015	7	24	6	24	8	0.3	3.9	0.69	97.7	86.9029	55.9078
2015	7	24	6	34	8	0.3	3.9	0.71	96.1	86.8373	57.7532
2015	7	24	6	44	8	0.3	3.9	0.72	97.3	86.8373	59.1026
2015	7	24	6	54	8	0.3	3.9	0.73	96.5	86.9029	59.419
2015	7	24	7	4	8	0.3	3.9	0.72	95.8	86.9029	58.6087
2015	7	24	7	14	8	0.3	3.9	0.73	96.4	86.8373	59.9122
2015	7	24	7	24	8	0.3	3.9	0.71	98.2	86.8373	57.7532
2015	7	24	7	34	8	0.3	3.9	0.68	97.2	86.9029	55.6378
2015	7	24	7	44	8	0.3	3.9	0.7	97	86.8373	56.9436
2015	7	24	7	54	8	0.3	3.9	0.75	97.3	86.9029	61.3096
2015	7	24	8	4	8	0.3	3.9	0.69	94.3	86.9029	56.9882
2015	7	24	8	14	8	0.3	3.9	0.7	96.2	86.9029	56.9882
2015	7	24	8	24	8	0.3	3.9	0.68	96.6	86.9029	55.6378
2015	7	24	8	34	8	0.3	3.9	0.72	98.9	86.8373	58.8327
2015	7	24	8	44	8	0.3	3.9	0.71	95.6	86.9029	57.7985
2015	7	24	8	54	8	0.3	3.9	0.73	97.5	86.8373	59.3724
2015	7	24	9	4	8	0.3	3.9	0.73	99	86.8373	59.6423
2015	7	24	9	14	8	0.3	3.9	0.73	98.3	86.8373	59.3724
2015	7	24	9	24	8	0.3	3.9	0.7	100.5	86.8373	56.9436
2015	7	24	9	34	8	0.3	3.9	0.73	96.9	86.8373	59.9122
2015	7	24	9	44	8	0.3	3.9	0.71	100.1	86.8373	57.7532
2015	7	24	9	54	8	0.3	3.9	0.71	101.2	86.8373	57.4833
2015	7	24	10	4	8	0.3	3.9	0.72	100.7	86.8373	58.5628
2015	7	24	10	14	8	0.3	3.9	0.69	98.4	86.8373	56.4038
2015	7	24	10	24	8	0.3	3.9	0.74	101.3	86.8373	59.3724
2015	7	24	10	34	8	0.3	3.9	0.71	96.9	86.8373	58.2929
2015	7	24	10	44	8	0.3	3.9	0.74	101.3	86.8373	59.6422
2015	7	24	10	54	8	0.3	3.9	0.72	98.4	86.7717	58.7864
2015	7	24	11	4	8	0.3	3.9	0.74	97.9	86.7717	59.8651
2015	7	24	11	14	8	0.3	3.9	0.72	98.4	86.7717	58.5167
2015	7	24	11	24	8	0.3	3.9	0.72	98.2	86.7717	58.2471
2015	7	24	11	34	8	0.3	3.9	0.72	96.3	86.7717	58.7864
2015	7	24	11	44	8	0.3	3.9	0.7	97.5	86.7717	57.4381
2015	7	24	11	54	8	0.3	3.9	0.73	100.4	86.7717	59.056

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	24	12	4	8	0.3	3.9	0.74	100.7	86.706	59.818
2015	7	24	12	14	8	0.3	3.9	0.7	99.4	86.706	57.1235
2015	7	24	12	24	8	0.3	3.9	0.71	100.9	86.706	57.1235
2015	7	24	12	34	8	0.3	3.9	0.73	98.5	86.706	59.5485
2015	7	24	12	44	8	0.3	3.9	0.75	104.4	86.5748	59.724
2015	7	24	12	54	8	0.3	3.9	0.75	100.3	86.5748	60.8001
2015	7	24	13	4	8	0.3	3.9	0.73	99.3	86.5748	59.186
2015	7	24	13	14	8	0.3	3.9	0.71	101.2	86.5748	57.3028
2015	7	24	13	24	8	0.3	3.9	0.71	98.5	86.5092	57.7953
2015	7	24	13	34	8	0.3	3.9	0.72	98.1	86.5092	58.6018
2015	7	24	13	44	8	0.3	3.9	0.69	101.3	86.5092	55.1072
2015	7	24	13	54	8	0.3	3.9	0.71	99.3	86.5092	57.2577
2015	7	24	14	4	8	0.3	3.9	0.71	102.2	86.4436	56.944
2015	7	24	14	14	8	0.3	3.9	0.72	100.5	86.4436	58.0184
2015	7	24	14	24	8	0.3	3.9	0.72	99.8	86.5092	57.7953
2015	7	24	14	34	8	0.3	3.9	0.71	100.1	86.4436	57.2126
2015	7	24	14	44	8	0.3	3.9	0.71	103.8	86.378	56.6307
2015	7	24	14	54	8	0.3	3.9	0.72	101.4	86.378	57.4359
2015	7	24	15	4	8	0.3	3.9	0.71	100.6	86.378	57.1675
2015	7	24	15	14	8	0.3	3.9	0.71	101.7	86.378	57.1675
2015	7	24	15	24	8	0.3	3.9	0.72	98.4	86.378	58.5095
2015	7	24	15	34	8	0.3	3.9	0.71	101.4	86.378	57.1675
2015	7	24	15	44	8	0.3	3.9	0.72	100.3	86.378	57.7043
2015	7	24	15	54	8	0.3	3.9	0.72	98.1	86.378	58.2411
2015	7	24	16	4	8	0.3	3.9	0.72	101.9	86.3123	57.3906
2015	7	24	16	14	8	0.3	3.9	0.73	99.3	86.3123	58.9997
2015	7	24	16	24	8	0.3	3.9	0.73	95.4	86.3123	59.5361
2015	7	24	16	34	8	0.3	3.9	0.74	99.5	86.3123	59.5361
2015	7	24	16	44	8	0.3	3.9	0.73	100.8	86.3123	58.9997
2015	7	24	16	54	8	0.3	3.9	0.74	100	86.3123	59.5361
2015	7	24	17	4	8	0.3	3.9	0.74	98.4	86.3123	59.8043
2015	7	24	17	14	8	0.3	3.9	0.71	99.6	86.3123	57.1225
2015	7	24	17	24	8	0.3	3.9	0.74	97.9	86.2467	59.7571
2015	7	24	17	34	8	0.3	3.9	0.73	98.1	86.3123	58.7316
2015	7	24	17	44	8	0.3	3.9	0.71	98	86.2467	57.3454
2015	7	24	17	54	8	0.3	3.9	0.74	99.4	86.2467	59.7571
2015	7	24	18	4	8	0.3	3.9	0.75	98.8	86.2467	60.829
2015	7	24	18	14	8	0.3	3.9	0.77	98.8	86.3123	62.2179
2015	7	24	18	24	8	0.3	3.9	0.75	97.8	86.3123	60.877
2015	7	24	18	34	8	0.3	3.9	0.72	99.8	86.3123	57.6589
2015	7	24	18	44	8	0.3	3.9	0.72	98.9	86.3123	58.4634
2015	7	24	18	54	8	0.3	3.9	0.72	96.8	86.3123	58.7316
2015	7	24	19	4	8	0.3	3.9	0.71	99.6	86.3123	56.8543
2015	7	24	19	14	8	0.3	3.9	0.73	99.3	86.3123	59.2679
2015	7	24	19	24	8	0.3	3.9	0.72	95.8	86.3123	58.4634
2015	7	24	19	34	8	0.3	3.9	0.67	97.1	86.3123	54.1725
2015	7	24	19	44	8	0.3	3.9	0.72	98.7	86.3123	57.927

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	24	19	54	8	0.3	3.9	0.69	97.1	86.3123	56.0497
2015	7	24	20	4	8	0.3	3.9	0.73	94.7	86.3123	59.2679
2015	7	24	20	14	8	0.3	3.9	0.73	95.9	86.3123	59.2679
2015	7	24	20	24	8	0.3	3.9	0.68	94.9	86.3123	55.7815
2015	7	24	20	34	8	0.3	3.9	0.68	97.2	86.3123	55.5133
2015	7	24	20	44	8	0.3	3.9	0.72	96.3	86.3123	58.4633
2015	7	24	20	54	8	0.3	3.9	0.71	96.4	86.3123	57.6588
2015	7	24	21	4	8	0.3	3.9	0.73	96.5	86.3123	59.2678
2015	7	24	21	14	8	0.3	3.9	0.71	98	86.3123	57.1224
2015	7	24	21	24	8	0.3	3.9	0.67	95.9	86.3123	54.4406
2015	7	24	21	34	8	0.3	3.9	0.73	98	86.3123	59.2678
2015	7	24	21	44	8	0.3	3.9	0.69	97.3	86.3123	56.3178
2015	7	24	21	54	8	0.3	3.9	0.71	97.2	86.3123	57.3906
2015	7	24	22	4	8	0.3	3.9	0.68	100.1	86.3123	54.4406
2015	7	24	22	14	8	0.3	3.9	0.68	96.6	86.3123	55.5133
2015	7	24	22	24	8	0.3	3.9	0.7	95.9	86.3123	56.8542
2015	7	24	22	34	8	0.3	3.9	0.69	96.6	86.378	55.8255
2015	7	24	22	44	8	0.3	3.9	0.69	99	86.378	56.0939
2015	7	24	22	54	8	0.3	3.9	0.72	96.8	86.378	58.5094
2015	7	24	23	4	8	0.3	3.9	0.68	95.8	86.378	55.2887
2015	7	24	23	14	8	0.3	3.9	0.66	94.9	86.378	53.6783
2015	7	24	23	24	8	0.3	3.9	0.7	95.4	86.378	56.6307
2015	7	24	23	34	8	0.3	3.9	0.67	95.9	86.378	54.2151
2015	7	24	23	44	8	0.3	3.9	0.67	97.6	86.378	54.4835
2015	7	24	23	54	8	0.3	3.9	0.7	99.2	86.378	56.3623
2015	7	25	0	4	8	0.3	3.9	0.71	95.6	86.378	57.4358
2015	7	25	0	14	8	0.3	3.9	0.7	98.9	86.378	56.6307
2015	7	25	0	24	8	0.3	3.9	0.72	95.8	86.378	58.241
2015	7	25	0	34	8	0.3	3.9	0.69	99	86.378	56.0939
2015	7	25	0	44	8	0.3	3.9	0.73	96.2	86.378	59.583
2015	7	25	0	54	8	0.3	3.9	0.68	94.4	86.378	55.8255
2015	7	25	1	4	8	0.3	3.9	0.71	96.1	86.378	57.4359
2015	7	25	1	14	8	0.3	3.9	0.69	95.5	86.378	56.0939
2015	7	25	1	24	8	0.3	3.9	0.74	96.4	86.378	60.1198
2015	7	25	1	34	8	0.3	3.9	0.69	94.9	86.378	56.0939
2015	7	25	1	44	8	0.3	3.9	0.66	93.4	86.378	54.2152
2015	7	25	1	54	8	0.3	3.9	0.69	96.3	86.378	56.0939
2015	7	25	2	4	8	0.3	3.9	0.73	97.8	86.378	58.7779
2015	7	25	2	14	8	0.3	3.9	0.72	96.5	86.378	58.5095
2015	7	25	2	24	8	0.3	3.9	0.68	95.5	86.378	55.2888
2015	7	25	2	34	8	0.3	3.9	0.74	97.3	86.378	60.3883
2015	7	25	2	44	8	0.3	3.9	0.72	96	86.378	58.5095
2015	7	25	2	54	8	0.3	3.9	0.71	98	86.378	57.1676
2015	7	25	3	4	8	0.3	3.9	0.7	96.4	86.378	57.1676
2015	7	25	3	14	8	0.3	3.9	0.75	97.3	86.378	60.9251
2015	7	25	3	24	8	0.3	3.9	0.69	96.9	86.378	55.8257
2015	7	25	3	34	8	0.3	3.9	0.71	95.6	86.378	57.7044

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	25	3	44	8	0.3	3.9	0.72	98.1	86.4436	58.2871
2015	7	25	3	54	8	0.3	3.9	0.69	95.7	86.4436	56.1383
2015	7	25	4	4	8	0.3	3.9	0.68	95.8	86.4436	55.6011
2015	7	25	4	14	8	0.3	3.9	0.68	96.6	86.4436	55.6011
2015	7	25	4	24	8	0.3	3.9	0.69	96.5	86.4436	56.407
2015	7	25	4	34	8	0.3	3.9	0.71	96.1	86.4436	57.4814
2015	7	25	4	44	8	0.3	3.9	0.69	94.9	86.4436	56.6756
2015	7	25	4	54	8	0.3	3.9	0.71	98.2	86.4436	57.4814
2015	7	25	5	4	8	0.3	3.9	0.72	96.3	86.4436	58.5559
2015	7	25	5	14	8	0.3	3.9	0.71	96.1	86.4436	57.4815
2015	7	25	5	24	8	0.3	3.9	0.72	99.9	86.4436	58.2873
2015	7	25	5	34	8	0.3	3.9	0.74	98.7	86.4436	59.8989
2015	7	25	5	44	8	0.3	3.9	0.68	95.2	86.4436	55.6013
2015	7	25	5	54	8	0.3	3.9	0.7	97	86.4436	56.6757
2015	7	25	6	4	8	0.3	3.9	0.69	97.9	86.4436	55.8699
2015	7	25	6	14	8	0.3	3.9	0.73	97.7	86.4436	59.3618
2015	7	25	6	24	8	0.3	3.9	0.69	95.7	86.5748	56.227
2015	7	25	6	34	8	0.3	3.9	0.68	94.4	86.5092	55.914
2015	7	25	6	44	8	0.3	3.9	0.73	97.5	86.5092	59.4086
2015	7	25	6	54	8	0.3	3.9	0.72	96.8	86.5748	58.3792
2015	7	25	7	4	8	0.3	3.9	0.68	97.5	86.5748	55.4199
2015	7	25	7	14	8	0.3	3.9	0.71	97.7	86.5748	57.8412
2015	7	25	7	24	8	0.3	3.9	0.69	92.7	86.5748	56.7651
2015	7	25	7	34	8	0.3	3.9	0.69	96	86.5748	55.958
2015	7	25	7	44	8	0.3	3.9	0.73	95.4	86.5748	59.4554
2015	7	25	7	54	8	0.3	3.9	0.71	95.8	86.5748	58.1102
2015	7	25	8	4	8	0.3	3.9	0.7	98.3	86.5748	57.0341
2015	7	25	8	14	8	0.3	3.9	0.69	99.8	86.5748	55.958
2015	7	25	8	24	8	0.3	3.9	0.7	99.5	86.5748	56.227
2015	7	25	8	34	8	0.3	3.9	0.69	96.5	86.5748	56.4961
2015	7	25	8	44	8	0.3	3.9	0.69	96.8	86.5748	56.227
2015	7	25	8	54	8	0.3	3.9	0.71	96.7	86.5092	57.5269
2015	7	25	9	4	8	0.3	3.9	0.7	96.8	86.5092	56.7204
2015	7	25	9	14	8	0.3	3.9	0.73	95.7	86.5092	59.4086
2015	7	25	9	24	8	0.3	3.9	0.75	98.8	86.4436	60.4363
2015	7	25	9	34	8	0.3	3.9	0.72	97.4	86.4436	58.2874
2015	7	25	9	44	8	0.3	3.9	0.72	99.4	86.378	58.2415
2015	7	25	9	54	8	0.3	3.9	0.74	98.9	86.378	59.8518
2015	7	25	10	4	8	0.3	3.9	0.69	98.2	86.378	56.0943
2015	7	25	10	14	8	0.3	3.9	0.73	99.6	86.378	58.5098
2015	7	25	10	24	8	0.3	3.9	0.7	99.4	86.378	56.6311
2015	7	25	10	34	8	0.3	3.9	0.72	100.2	86.3123	57.9273
2015	7	25	10	44	8	0.3	3.9	0.71	99.3	86.3123	57.3909
2015	7	25	10	54	8	0.3	3.9	0.7	100.7	86.3123	56.5864
2015	7	25	11	4	8	0.3	3.9	0.72	101.1	86.3123	57.6591
2015	7	25	11	14	8	0.3	3.9	0.7	99.9	86.3123	56.5864
2015	7	25	11	24	8	0.3	3.9	0.7	101.1	86.3123	56.05

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	25	11	34	8	0.3	3.9	0.7	100.7	86.3123	56.5863
2015	7	25	11	44	8	0.3	3.9	0.74	100.5	86.3123	59.2681
2015	7	25	11	54	8	0.3	3.9	0.69	101.3	86.3123	54.9772
2015	7	25	12	4	8	0.3	3.9	0.74	100.3	86.3123	59.2681
2015	7	25	12	14	8	0.3	3.9	0.69	103.4	86.3123	54.9772
2015	7	25	12	24	8	0.3	3.9	0.7	100.8	86.3123	56.0499
2015	7	25	12	34	8	0.3	3.9	0.69	101.6	86.3123	54.9772
2015	7	25	12	44	8	0.3	3.9	0.72	98.6	86.3123	58.1953
2015	7	25	12	54	8	0.3	3.9	0.74	99.8	86.2467	59.2213
2015	7	25	13	4	8	0.3	3.9	0.72	98.2	86.3123	57.9271
2015	7	25	13	14	8	0.3	3.9	0.72	102.1	86.2467	57.3455
2015	7	25	13	24	8	0.3	3.9	0.73	106.6	86.2467	56.8095
2015	7	25	13	34	8	0.3	3.9	0.69	102.3	86.2467	55.4697
2015	7	25	13	44	8	0.3	3.9	0.71	102.2	86.2467	56.8095
2015	7	25	13	54	8	0.3	3.9	0.73	98.6	86.1811	58.639
2015	7	25	14	4	8	0.3	3.9	0.71	98.2	86.2467	57.6134
2015	7	25	14	14	8	0.3	3.9	0.72	101.8	86.1811	57.8357
2015	7	25	14	24	8	0.3	3.9	0.71	105.3	86.1811	55.6936
2015	7	25	14	34	8	0.3	3.9	0.67	101.8	86.1811	53.8193
2015	7	25	14	44	8	0.3	3.9	0.67	101.6	86.1155	53.5092
2015	7	25	14	54	8	0.3	3.9	0.72	101.1	86.1155	57.5225
2015	7	25	15	4	8	0.3	3.9	0.64	99.5	86.1155	51.1013
2015	7	25	15	14	8	0.3	3.9	0.71	103.7	86.1155	55.9172
2015	7	25	15	24	8	0.3	3.9	0.69	100.5	86.1155	55.1145
2015	7	25	15	34	8	0.3	3.9	0.7	98.1	86.0499	56.4076
2015	7	25	15	44	8	0.3	3.9	0.74	101.8	86.0499	58.8137
2015	7	25	15	54	8	0.3	3.9	0.66	100.1	86.0499	52.665
2015	7	25	16	4	8	0.3	3.9	0.7	98.6	86.0499	56.675
2015	7	25	16	14	8	0.3	3.9	0.68	102	86.0499	54.0016
2015	7	25	16	24	8	0.3	3.9	0.74	99.7	85.9843	59.3014
2015	7	25	16	34	8	0.3	3.9	0.75	100.1	85.9843	59.8356
2015	7	25	16	44	8	0.3	3.9	0.72	100.7	85.9843	57.6986
2015	7	25	16	54	8	0.3	3.9	0.69	98.2	86.0499	55.873
2015	7	25	17	4	8	0.3	3.9	0.72	99.5	85.9843	57.4315
2015	7	25	17	14	8	0.3	3.9	0.71	97.4	85.9843	57.6987
2015	7	25	17	24	8	0.3	3.9	0.7	98.6	85.9843	56.6302
2015	7	25	17	34	8	0.3	3.9	0.69	99.1	85.9843	55.2946
2015	7	25	17	44	8	0.3	3.9	0.72	98.4	85.9843	57.9658
2015	7	25	17	54	8	0.3	3.9	0.68	102.6	85.9843	53.6918
2015	7	25	18	4	8	0.3	3.9	0.69	102.6	85.9186	54.717
2015	7	25	18	14	8	0.3	3.9	0.71	98.3	85.9186	56.8523
2015	7	25	18	24	8	0.3	3.9	0.69	102.6	85.9186	54.9839
2015	7	25	18	34	8	0.3	3.9	0.72	101	85.9843	57.6987
2015	7	25	18	44	8	0.3	3.9	0.72	103	85.9843	56.8973
2015	7	25	18	54	8	0.3	3.9	0.7	101.4	85.9843	55.5617
2015	7	25	19	4	8	0.3	3.9	0.7	97.3	85.9843	56.6302
2015	7	25	19	14	8	0.3	3.9	0.71	99.3	85.853	57.0739

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	25	19	24	8	0.3	3.9	0.7	97.9	85.9186	56.0515
2015	7	25	19	34	8	0.3	3.9	0.69	96	85.9186	56.0515
2015	7	25	19	44	8	0.3	3.9	0.71	95	85.9186	57.9199
2015	7	25	19	54	8	0.3	3.9	0.72	98.9	85.9186	58.1868
2015	7	25	20	4	8	0.3	3.9	0.7	96.7	85.9843	56.8973
2015	7	25	20	14	8	0.3	3.9	0.71	95.1	85.9843	57.4315
2015	7	25	20	24	8	0.3	3.9	0.67	95	85.9843	54.4931
2015	7	25	20	34	8	0.3	3.9	0.72	95.8	85.9843	57.9657
2015	7	25	20	44	8	0.3	3.9	0.72	97.6	85.9843	57.9657
2015	7	25	20	54	8	0.3	3.9	0.64	96.4	85.9843	52.089
2015	7	25	21	4	8	0.3	3.9	0.7	97.3	85.9186	56.5852
2015	7	25	21	14	8	0.3	3.9	0.7	98.3	85.9843	56.6301
2015	7	25	21	24	8	0.3	3.9	0.72	97.9	85.9843	57.6986
2015	7	25	21	34	8	0.3	3.9	0.7	96.5	85.9843	56.6301
2015	7	25	21	44	8	0.3	3.9	0.7	95.7	85.9843	56.3629
2015	7	25	21	54	8	0.3	3.9	0.68	97.7	85.9843	55.0273
2015	7	25	22	4	8	0.3	3.9	0.71	97.2	86.0499	57.4769
2015	7	25	22	14	8	0.3	3.9	0.7	98.3	86.0499	56.6749
2015	7	25	22	24	8	0.3	3.9	0.71	96.1	86.0499	57.7442
2015	7	25	22	34	8	0.3	3.9	0.7	95.7	86.0499	56.4076
2015	7	25	22	44	8	0.3	3.9	0.68	93.3	86.0499	55.6056
2015	7	25	22	54	8	0.3	3.9	0.7	95.9	86.0499	56.6749
2015	7	25	23	4	8	0.3	3.9	0.69	96.6	86.0499	55.6056
2015	7	25	23	14	8	0.3	3.9	0.68	97.2	86.0499	55.0709
2015	7	25	23	24	8	0.3	3.9	0.7	97.3	86.0499	56.6749
2015	7	25	23	34	8	0.3	3.9	0.68	94.4	86.0499	55.6056
2015	7	25	23	44	8	0.3	3.9	0.69	93	86.0499	56.4076
2015	7	25	23	54	8	0.3	3.9	0.66	95.1	86.0499	53.7342
2015	7	26	0	4	8	0.3	3.9	0.7	96.5	86.0499	56.6749
2015	7	26	0	14	8	0.3	3.9	0.67	95.6	86.0499	54.5362
2015	7	26	0	24	8	0.3	3.9	0.71	95.6	86.0499	57.4769
2015	7	26	0	34	8	0.3	3.9	0.69	97.3	86.0499	56.1403
2015	7	26	0	44	8	0.3	3.9	0.69	94.6	86.0499	56.1403
2015	7	26	0	54	8	0.3	3.9	0.69	96.9	86.0499	55.6056
2015	7	26	1	4	8	0.3	3.9	0.7	97	86.0499	56.4076
2015	7	26	1	14	8	0.3	3.9	0.68	98.3	86.0499	55.0709
2015	7	26	1	24	8	0.3	3.9	0.66	95.4	86.1155	53.5092
2015	7	26	1	34	8	0.3	3.9	0.69	94.3	86.0499	56.4076
2015	7	26	1	44	8	0.3	3.9	0.69	98.2	86.0499	55.3383
2015	7	26	1	54	8	0.3	3.9	0.68	97.2	86.0499	55.071
2015	7	26	2	4	8	0.3	3.9	0.71	97.4	86.0499	57.7443
2015	7	26	2	14	8	0.3	3.9	0.73	97.8	86.0499	58.5464
2015	7	26	2	24	8	0.3	3.9	0.7	97	86.1155	56.4523
2015	7	26	2	34	8	0.3	3.9	0.68	94.2	86.1155	55.1146
2015	7	26	2	44	8	0.3	3.9	0.7	98.1	86.1155	56.7199
2015	7	26	2	54	8	0.3	3.9	0.72	96.8	86.0499	58.0117
2015	7	26	3	4	8	0.3	3.9	0.73	98	86.0499	58.8138

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	26	3	14	8	0.3	3.9	0.72	97.1	86.1155	58.3252
2015	7	26	3	24	8	0.3	3.9	0.68	94.4	86.1155	55.6498
2015	7	26	3	34	8	0.3	3.9	0.69	94.3	86.0499	56.4078
2015	7	26	3	44	8	0.3	3.9	0.72	97.9	86.0499	57.7445
2015	7	26	3	54	8	0.3	3.9	0.7	97.8	86.0499	56.4078
2015	7	26	4	4	8	0.3	3.9	0.69	95.7	86.1155	55.9174
2015	7	26	4	14	8	0.3	3.9	0.67	97.3	86.1155	54.3121
2015	7	26	4	24	8	0.3	3.9	0.69	97.7	86.1155	55.3823
2015	7	26	4	34	8	0.3	3.9	0.7	96.8	86.0499	56.4079
2015	7	26	4	44	8	0.3	3.9	0.67	95.9	86.0499	54.5366
2015	7	26	4	54	8	0.3	3.9	0.7	99.7	86.0499	56.4079
2015	7	26	5	4	8	0.3	3.9	0.71	96.1	86.0499	57.7446
2015	7	26	5	14	8	0.3	3.9	0.72	97.9	86.0499	58.012
2015	7	26	5	24	8	0.3	3.9	0.71	96.6	86.0499	57.4773
2015	7	26	5	34	8	0.3	3.9	0.69	100.2	86.0499	55.0713
2015	7	26	5	44	8	0.3	3.9	0.67	97.1	86.0499	54.002
2015	7	26	5	54	8	0.3	3.9	0.72	97.4	86.0499	58.0121
2015	7	26	6	4	8	0.3	3.9	0.69	97.1	86.0499	56.1407
2015	7	26	6	14	8	0.3	3.9	0.74	97.1	86.0499	59.8834
2015	7	26	6	24	8	0.3	3.9	0.69	96	86.0499	55.6061
2015	7	26	6	34	8	0.3	3.9	0.75	97	86.0499	60.6855
2015	7	26	6	44	8	0.3	3.9	0.7	97.9	86.0499	56.1408
2015	7	26	6	54	8	0.3	3.9	0.71	96.6	86.0499	57.7448
2015	7	26	7	4	8	0.3	3.9	0.71	95.3	86.0499	57.2101
2015	7	26	7	14	8	0.3	3.9	0.71	95.3	86.0499	58.0122
2015	7	26	7	24	8	0.3	3.9	0.69	96.8	86.0499	56.1408
2015	7	26	7	34	8	0.3	3.9	0.7	98.4	86.0499	56.4082
2015	7	26	7	44	8	0.3	3.9	0.7	96.8	86.0499	56.4082
2015	7	26	7	54	8	0.3	3.9	0.72	96.8	86.0499	58.5469
2015	7	26	8	4	8	0.3	3.9	0.7	96.5	86.0499	56.4082
2015	7	26	8	14	8	0.3	3.9	0.71	99.3	86.0499	57.2102
2015	7	26	8	24	8	0.3	3.9	0.71	96.1	86.0499	57.4775
2015	7	26	8	34	8	0.3	3.9	0.7	99.8	86.0499	55.8735
2015	7	26	8	44	8	0.3	3.9	0.72	98.1	86.0499	58.0122
2015	7	26	8	54	8	0.3	3.9	0.71	97.2	86.0499	57.4775
2015	7	26	9	4	8	0.3	3.9	0.74	97.7	86.0499	59.6162
2015	7	26	9	14	8	0.3	3.9	0.72	96.8	86.0499	58.5468
2015	7	26	9	24	8	0.3	3.9	0.73	97.8	86.0499	58.8141
2015	7	26	9	34	8	0.3	3.9	0.7	97.5	86.0499	56.6754
2015	7	26	9	44	8	0.3	3.9	0.68	99.4	86.0499	54.8041
2015	7	26	9	54	8	0.3	3.9	0.73	99	86.0499	59.0815
2015	7	26	10	4	8	0.3	3.9	0.71	98	86.0499	57.2101
2015	7	26	10	14	8	0.3	3.9	0.71	96.9	86.0499	57.2101
2015	7	26	10	24	8	0.3	3.9	0.71	101.2	86.0499	56.9427
2015	7	26	10	34	8	0.3	3.9	0.72	101.8	86.0499	57.7447
2015	7	26	10	44	8	0.3	3.9	0.71	100.7	86.0499	56.6754
2015	7	26	10	54	8	0.3	3.9	0.69	101	85.9843	54.7606

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	26	11	4	8	0.3	3.9	0.69	100.7	85.9843	55.0277
2015	7	26	11	14	8	0.3	3.9	0.72	102.6	85.9843	57.1647
2015	7	26	11	24	8	0.3	3.9	0.69	101	85.9843	54.7606
2015	7	26	11	34	8	0.3	3.9	0.7	100.7	85.9843	56.3633
2015	7	26	11	44	8	0.3	3.9	0.68	101.4	85.9186	54.1834
2015	7	26	11	54	8	0.3	3.9	0.71	100.2	85.9186	56.5856
2015	7	26	12	4	8	0.3	3.9	0.71	98.5	85.9186	57.3863
2015	7	26	12	14	8	0.3	3.9	0.7	104.2	85.9186	54.9841
2015	7	26	12	24	8	0.3	3.9	0.68	101.4	85.853	54.1404
2015	7	26	12	34	8	0.3	3.9	0.7	103.3	85.853	55.4739
2015	7	26	12	44	8	0.3	3.9	0.69	101.7	85.853	55.2071
2015	7	26	12	54	8	0.3	3.9	0.7	101.8	85.853	56.0072
2015	7	26	13	4	8	0.3	3.9	0.7	102.2	85.7874	55.6963
2015	7	26	13	14	8	0.3	3.9	0.71	101	85.7874	56.2293
2015	7	26	13	24	8	0.3	3.9	0.69	102.1	85.7218	54.587
2015	7	26	13	34	8	0.3	3.9	0.67	100.2	85.7874	53.5644
2015	7	26	13	44	8	0.3	3.9	0.69	101.8	85.7218	54.8532
2015	7	26	13	54	8	0.3	3.9	0.72	102.1	85.7218	56.9834
2015	7	26	14	4	8	0.3	3.9	0.7	101.2	85.5906	55.2978
2015	7	26	14	14	8	0.3	3.9	0.7	101.3	85.6562	55.8739
2015	7	26	14	24	8	0.3	3.9	0.68	99.1	85.6562	54.8096
2015	7	26	14	34	8	0.3	3.9	0.71	97.2	85.5906	57.1587
2015	7	26	14	44	8	0.3	3.9	0.69	101.5	85.6562	54.8096
2015	7	26	14	54	8	0.3	3.9	0.69	100.6	85.6562	55.3418
2015	7	26	15	4	8	0.3	3.9	0.69	99.6	85.5906	54.7661
2015	7	26	15	14	8	0.3	3.9	0.69	94.6	85.5906	55.8295
2015	7	26	15	24	8	0.3	3.9	0.69	102.6	85.5249	54.4568
2015	7	26	15	34	8	0.3	3.9	0.71	100.2	85.5249	56.3164
2015	7	26	15	44	8	0.3	3.9	0.7	100.2	85.5249	56.0507
2015	7	26	15	54	8	0.3	3.9	0.67	95.4	85.5906	53.7027
2015	7	26	16	4	8	0.3	3.9	0.69	99.6	85.5249	54.9882
2015	7	26	16	14	8	0.3	3.9	0.66	99.4	85.5249	52.863
2015	7	26	16	24	8	0.3	3.9	0.68	99.1	85.5249	54.7225
2015	7	26	16	34	8	0.3	3.9	0.72	96.3	85.5249	57.6446
2015	7	26	16	44	8	0.3	3.9	0.7	99.9	85.4593	56.0061
2015	7	26	16	54	8	0.3	3.9	0.7	99.7	85.4593	55.7407
2015	7	26	17	4	8	0.3	3.9	0.73	99.5	85.4593	58.395
2015	7	26	17	14	8	0.3	3.9	0.7	101.6	85.4593	55.4753
2015	7	26	17	24	8	0.3	3.9	0.67	100.1	85.4593	53.6173
2015	7	26	17	34	8	0.3	3.9	0.69	99.6	85.3937	54.9006
2015	7	26	17	44	8	0.3	3.9	0.74	101.5	85.3937	58.6137
2015	7	26	17	54	8	0.3	3.9	0.71	99.1	85.3281	56.4469
2015	7	26	18	4	8	0.3	3.9	0.74	100.5	85.3281	58.567
2015	7	26	18	14	8	0.3	3.9	0.7	98.1	85.3937	56.2267
2015	7	26	18	24	8	0.3	3.9	0.69	100.4	85.3937	54.9006
2015	7	26	18	34	8	0.3	3.9	0.72	99.5	85.3281	56.9769
2015	7	26	18	44	8	0.3	3.9	0.71	96.6	85.3937	57.2876

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	26	18	54	8	0.3	3.9	0.72	96.8	85.3281	57.5069
2015	7	26	19	4	8	0.3	3.9	0.72	100.7	85.3281	57.2419
2015	7	26	19	14	8	0.3	3.9	0.7	99.5	85.3281	55.3868
2015	7	26	19	24	8	0.3	3.9	0.7	96.7	85.3281	56.1819
2015	7	26	19	34	8	0.3	3.9	0.73	98.2	85.3281	58.5669
2015	7	26	19	44	8	0.3	3.9	0.67	98.8	85.3281	53.2668
2015	7	26	19	54	8	0.3	3.9	0.67	98.1	85.3281	53.7968
2015	7	26	20	4	8	0.3	3.9	0.68	98.1	85.3937	54.3701
2015	7	26	20	14	8	0.3	3.9	0.69	95.7	85.3937	55.431
2015	7	26	20	24	8	0.3	3.9	0.69	97.3	85.3937	55.6962
2015	7	26	20	34	8	0.3	3.9	0.71	95	85.3937	57.5528
2015	7	26	20	44	8	0.3	3.9	0.66	96.8	85.3937	53.3092
2015	7	26	20	54	8	0.3	3.9	0.7	96.4	85.3937	56.4919
2015	7	26	21	4	8	0.3	3.9	0.68	98.8	85.3937	54.6353
2015	7	26	21	14	8	0.3	3.9	0.69	95.2	85.3937	55.6962
2015	7	26	21	24	8	0.3	3.9	0.69	96.6	85.3937	55.1658
2015	7	26	21	34	8	0.3	3.9	0.7	95.4	85.3937	56.2266
2015	7	26	21	44	8	0.3	3.9	0.65	98.7	85.3937	52.2483
2015	7	26	21	54	8	0.3	3.9	0.73	99	85.3937	58.3484
2015	7	26	22	4	8	0.3	3.9	0.72	96.8	85.3937	57.5527
2015	7	26	22	14	8	0.3	3.9	0.68	96.9	85.3937	54.6353
2015	7	26	22	24	8	0.3	3.9	0.68	99.4	85.3937	54.3701
2015	7	26	22	34	8	0.3	3.9	0.69	95.5	85.3937	55.431
2015	7	26	22	44	8	0.3	3.9	0.69	96.3	85.3937	55.431
2015	7	26	22	54	8	0.3	3.9	0.7	98.4	85.3937	55.9614
2015	7	26	23	4	8	0.3	3.9	0.67	98.5	85.3937	53.3092
2015	7	26	23	14	8	0.3	3.9	0.67	97.3	85.3937	53.8396
2015	7	26	23	24	8	0.3	3.9	0.67	94.5	85.3937	54.3701
2015	7	26	23	34	8	0.3	3.9	0.69	97.1	85.3937	55.431
2015	7	26	23	44	8	0.3	3.9	0.7	94.6	85.3937	56.4918
2015	7	26	23	54	8	0.3	3.9	0.71	97.2	85.3937	57.0223
2015	7	27	0	4	8	0.3	3.9	0.7	95.4	85.3937	56.2266
2015	7	27	0	14	8	0.3	3.9	0.68	96.1	85.3937	54.9005
2015	7	27	0	24	8	0.3	3.9	0.69	96	85.3937	55.1658
2015	7	27	0	34	8	0.3	3.9	0.68	97.2	85.3937	54.6353
2015	7	27	0	44	8	0.3	3.9	0.69	95.5	85.3937	55.431
2015	7	27	0	54	8	0.3	3.9	0.7	95.4	85.3937	55.9614
2015	7	27	1	4	8	0.3	3.9	0.68	98.6	85.3937	54.1049
2015	7	27	1	14	8	0.3	3.9	0.7	94.9	85.3937	56.2267
2015	7	27	1	24	8	0.3	3.9	0.72	98.7	85.4593	57.3332
2015	7	27	1	34	8	0.3	3.9	0.72	95.5	85.4593	58.1295
2015	7	27	1	44	8	0.3	3.9	0.71	94.5	85.4593	57.0678
2015	7	27	1	54	8	0.3	3.9	0.69	98.5	85.4593	54.9444
2015	7	27	2	4	8	0.3	3.9	0.71	96.1	85.4593	57.3333
2015	7	27	2	14	8	0.3	3.9	0.69	96	85.4593	55.2098
2015	7	27	2	24	8	0.3	3.9	0.69	94.9	85.4593	55.4753
2015	7	27	2	34	8	0.3	3.9	0.67	98.5	85.4593	53.3518

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	27	2	44	8	0.3	3.9	0.69	98.2	85.4593	55.4753
2015	7	27	2	54	8	0.3	3.9	0.7	101.8	85.4593	55.7407
2015	7	27	3	4	8	0.3	3.9	0.67	97	85.4593	54.1482
2015	7	27	3	14	8	0.3	3.9	0.69	94.1	85.4593	55.4753
2015	7	27	3	24	8	0.3	3.9	0.69	97.4	85.4593	55.2099
2015	7	27	3	34	8	0.3	3.9	0.71	96.7	85.4593	56.8025
2015	7	27	3	44	8	0.3	3.9	0.68	96.7	85.4593	54.4136
2015	7	27	3	54	8	0.3	3.9	0.7	96.2	85.4593	56.2717
2015	7	27	4	4	8	0.3	3.9	0.7	92.9	85.4593	56.8025
2015	7	27	4	14	8	0.3	3.9	0.68	97.2	85.4593	54.4137
2015	7	27	4	24	8	0.3	3.9	0.69	98.2	85.5249	55.5196
2015	7	27	4	34	8	0.3	3.9	0.7	93.5	85.4593	56.2717
2015	7	27	4	44	8	0.3	3.9	0.7	95.7	85.5249	56.3166
2015	7	27	4	54	8	0.3	3.9	0.7	97	85.4593	56.0063
2015	7	27	5	4	8	0.3	3.9	0.7	96.5	85.4593	56.0063
2015	7	27	5	14	8	0.3	3.9	0.68	95	85.4593	54.6791
2015	7	27	5	24	8	0.3	3.9	0.68	98.6	85.4593	54.4137
2015	7	27	5	34	8	0.3	3.9	0.7	98.4	85.3937	55.9617
2015	7	27	5	44	8	0.3	3.9	0.68	95	85.4593	54.6792
2015	7	27	5	54	8	0.3	3.9	0.67	98.8	85.3937	53.3095
2015	7	27	6	4	8	0.3	3.9	0.72	96.1	85.4593	57.5989
2015	7	27	6	14	8	0.3	3.9	0.69	96.3	85.4593	55.7409
2015	7	27	6	24	8	0.3	3.9	0.72	98.1	85.4593	57.5989
2015	7	27	6	34	8	0.3	3.9	0.7	98.9	85.5249	55.7854
2015	7	27	6	44	8	0.3	3.9	0.67	97.7	85.4593	53.352
2015	7	27	6	54	8	0.3	3.9	0.71	94.8	85.5249	57.3792
2015	7	27	7	4	8	0.3	3.9	0.68	94.1	85.5249	54.9884
2015	7	27	7	14	8	0.3	3.9	0.68	97.2	85.5249	54.4571
2015	7	27	7	24	8	0.3	3.9	0.7	98.1	85.5249	56.3167
2015	7	27	7	34	8	0.3	3.9	0.66	93.1	85.5249	53.3946
2015	7	27	7	44	8	0.3	3.9	0.68	98.6	85.5249	54.1915
2015	7	27	7	54	8	0.3	3.9	0.65	96.4	85.5249	52.0664
2015	7	27	8	4	8	0.3	3.9	0.66	98.3	85.5249	53.1289
2015	7	27	8	14	8	0.3	3.9	0.7	95.4	85.5249	56.051
2015	7	27	8	24	8	0.3	3.9	0.72	95.2	85.5249	57.9106
2015	7	27	8	34	8	0.3	3.9	0.71	95.1	85.5249	57.1136
2015	7	27	8	44	8	0.3	3.9	0.69	97.3	85.5249	55.7854
2015	7	27	8	54	8	0.3	3.9	0.67	96.5	85.5249	53.6603
2015	7	27	9	4	8	0.3	3.9	0.67	97.3	85.4593	54.1484
2015	7	27	9	14	8	0.3	3.9	0.67	97.3	85.4593	54.1484
2015	7	27	9	24	8	0.3	3.9	0.7	95.9	85.4593	56.5373
2015	7	27	9	34	8	0.3	3.9	0.69	96.3	85.4593	55.4755
2015	7	27	9	44	8	0.3	3.9	0.67	95.7	85.4593	53.6175
2015	7	27	9	54	8	0.3	3.9	0.68	98	85.3937	54.6356
2015	7	27	10	4	8	0.3	3.9	0.7	95.7	85.4593	56.2718
2015	7	27	10	14	8	0.3	3.9	0.69	98.5	85.3937	54.9008
2015	7	27	10	24	8	0.3	3.9	0.68	97.5	85.3937	54.6356

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	27	10	34	8	0.3	3.9	0.67	97	85.3937	54.1052
2015	7	27	10	44	8	0.3	3.9	0.69	96	85.3937	55.6965
2015	7	27	10	54	8	0.3	3.9	0.67	97.3	85.3281	53.797
2015	7	27	11	4	8	0.3	3.9	0.7	97.5	85.3281	56.1821
2015	7	27	11	14	8	0.3	3.9	0.71	96.6	85.3281	57.2421
2015	7	27	11	24	8	0.3	3.9	0.68	96.4	85.3281	54.592
2015	7	27	11	34	8	0.3	3.9	0.72	97.6	85.3281	57.2421
2015	7	27	11	44	8	0.3	3.9	0.71	98.2	85.2625	56.6668
2015	7	27	11	54	8	0.3	3.9	0.66	97.5	85.2625	52.43
2015	7	27	12	4	8	0.3	3.9	0.68	96.7	85.2625	54.2836
2015	7	27	12	14	8	0.3	3.9	0.71	98.3	85.2625	56.4019
2015	7	27	12	24	8	0.3	3.9	0.7	98.1	85.2625	56.1371
2015	7	27	12	34	8	0.3	3.9	0.7	99.4	85.1969	55.8277
2015	7	27	12	44	8	0.3	3.9	0.66	98.3	85.1969	52.9172
2015	7	27	12	54	8	0.3	3.9	0.68	97.5	85.1969	54.2401
2015	7	27	13	4	8	0.3	3.9	0.69	98.2	85.1969	55.2985
2015	7	27	13	14	8	0.3	3.9	0.69	97.6	85.1969	55.2985
2015	7	27	13	24	8	0.3	3.9	0.69	96.8	85.1969	55.5631
2015	7	27	13	34	8	0.3	3.9	0.67	99.3	85.1312	53.4036
2015	7	27	13	44	8	0.3	3.9	0.71	95.6	85.1312	57.1049
2015	7	27	13	54	8	0.3	3.9	0.71	96.1	85.1312	56.5761
2015	7	27	14	4	8	0.3	3.9	0.7	96.8	85.1312	55.783
2015	7	27	14	14	8	0.3	3.9	0.68	99.2	85.1312	53.9324
2015	7	27	14	24	8	0.3	3.9	0.68	97.2	85.0656	54.6817
2015	7	27	14	34	8	0.3	3.9	0.72	95.5	85.0656	57.8517
2015	7	27	14	44	8	0.3	3.9	0.69	99.9	85.0656	54.6817
2015	7	27	14	54	8	0.3	3.9	0.72	98.9	85.0656	57.5875
2015	7	27	15	4	8	0.3	3.9	0.66	98.3	85	52.2624
2015	7	27	15	14	8	0.3	3.9	0.69	98.2	84.9344	54.5942
2015	7	27	15	24	8	0.3	3.9	0.64	103.3	84.8688	50.0704
2015	7	27	15	34	8	0.3	3.9	0.7	99.4	84.8688	55.6045
2015	7	27	15	44	8	0.3	3.9	0.68	97.5	84.8688	54.2869
2015	7	27	15	54	8	0.3	3.9	0.7	99.8	84.8032	55.0332
2015	7	27	16	4	8	0.3	3.9	0.69	98.7	84.8032	54.7699
2015	7	27	16	14	8	0.3	3.9	0.72	102.4	84.8032	56.0865
2015	7	27	16	24	8	0.3	3.9	0.69	103	84.8032	53.7167
2015	7	27	16	34	8	0.3	3.9	0.68	97	84.8032	53.98
2015	7	27	16	44	8	0.3	3.9	0.68	99.1	84.8032	53.98
2015	7	27	16	54	8	0.3	3.9	0.68	99.7	84.8032	53.98
2015	7	27	17	4	8	0.3	3.9	0.71	100.7	84.8032	55.8232
2015	7	27	17	14	8	0.3	3.9	0.7	97.6	84.8032	55.5599
2015	7	27	17	24	8	0.3	3.9	0.74	97.9	84.8032	58.7197
2015	7	27	17	34	8	0.3	3.9	0.69	98.7	84.7375	54.726
2015	7	27	17	44	8	0.3	3.9	0.7	98.1	84.7375	55.7784
2015	7	27	17	54	8	0.3	3.9	0.68	98.6	84.7375	53.9367
2015	7	27	18	4	8	0.3	3.9	0.7	98.6	84.7375	55.5153
2015	7	27	18	14	8	0.3	3.9	0.72	97.4	84.7375	57.0939

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	27	18	24	8	0.3	3.9	0.68	98.6	84.7375	54.1998
2015	7	27	18	34	8	0.3	3.9	0.71	95	84.7375	56.8308
2015	7	27	18	44	8	0.3	3.9	0.69	98.4	84.7375	54.9891
2015	7	27	18	54	8	0.3	3.9	0.71	96.9	84.7375	56.3046
2015	7	27	19	4	8	0.3	3.9	0.66	95.7	84.8032	52.4001
2015	7	27	19	14	8	0.3	3.9	0.69	97.6	84.8032	55.0333
2015	7	27	19	24	8	0.3	3.9	0.7	95.7	84.8032	55.5599
2015	7	27	19	34	8	0.3	3.9	0.68	98.6	84.8032	54.2433
2015	7	27	19	44	8	0.3	3.9	0.68	97	84.8032	53.98
2015	7	27	19	54	8	0.3	3.9	0.67	97.9	84.8032	52.9267
2015	7	27	20	4	8	0.3	3.9	0.65	97.2	84.8032	51.8735
2015	7	27	20	14	8	0.3	3.9	0.71	96.4	84.8032	56.6132
2015	7	27	20	24	8	0.3	3.9	0.71	97.2	84.8032	56.6131
2015	7	27	20	34	8	0.3	3.9	0.68	98.6	84.8032	54.2433
2015	7	27	20	44	8	0.3	3.9	0.69	97.7	84.8032	54.5066
2015	7	27	20	54	8	0.3	3.9	0.69	96.6	84.8032	54.7699
2015	7	27	21	4	8	0.3	3.9	0.69	97.1	84.8032	55.0332
2015	7	27	21	14	8	0.3	3.9	0.66	97.4	84.8688	52.9692
2015	7	27	21	24	8	0.3	3.9	0.68	97.8	84.8688	53.7598
2015	7	27	21	34	8	0.3	3.9	0.7	100.8	84.8688	55.0774
2015	7	27	21	44	8	0.3	3.9	0.65	96.4	84.9344	51.693
2015	7	27	21	54	8	0.3	3.9	0.68	96.1	84.8688	54.0233
2015	7	27	22	4	8	0.3	3.9	0.67	94.7	84.9344	54.0666
2015	7	27	22	14	8	0.3	3.9	0.67	96.2	85	53.5821
2015	7	27	22	24	8	0.3	3.9	0.66	97.4	85	52.7902
2015	7	27	22	34	8	0.3	3.9	0.67	97.3	85	53.5821
2015	7	27	22	44	8	0.3	3.9	0.69	98.5	84.9344	54.5941
2015	7	27	22	54	8	0.3	3.9	0.67	94.5	85	54.11
2015	7	27	23	4	8	0.3	3.9	0.67	98.8	85.0656	53.0967
2015	7	27	23	14	8	0.3	3.9	0.7	97.8	85	55.6937
2015	7	27	23	24	8	0.3	3.9	0.69	98.2	85	55.1658
2015	7	27	23	34	8	0.3	3.9	0.67	95.6	85	53.8461
2015	7	27	23	44	8	0.3	3.9	0.69	97.1	85.0656	55.21
2015	7	27	23	54	8	0.3	3.9	0.68	98	85.0656	54.4175
2015	7	28	0	4	8	0.3	3.9	0.7	97.3	85.0656	55.7383
2015	7	28	0	14	8	0.3	3.9	0.67	98.7	85.0656	53.625
2015	7	28	0	24	8	0.3	3.9	0.67	95.1	85.0656	53.3609
2015	7	28	0	34	8	0.3	3.9	0.68	98.9	85.0656	54.1534
2015	7	28	0	44	8	0.3	3.9	0.65	94.6	85.0656	52.0401
2015	7	28	0	54	8	0.3	3.9	0.66	97.4	85.0656	53.0967
2015	7	28	1	4	8	0.3	3.9	0.67	95.9	85.0656	53.3609
2015	7	28	1	14	8	0.3	3.9	0.69	94.3	85.0656	55.7384
2015	7	28	1	24	8	0.3	3.9	0.69	96.3	85.1312	55.2542
2015	7	28	1	34	8	0.3	3.9	0.68	97.2	85.0656	54.4176
2015	7	28	1	44	8	0.3	3.9	0.68	97.5	85.0656	54.4176
2015	7	28	1	54	8	0.3	3.9	0.7	98.1	85.1312	55.783
2015	7	28	2	4	8	0.3	3.9	0.67	99.3	85.1312	53.4036

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	28	2	14	8	0.3	3.9	0.66	97.1	85.1312	53.1393
2015	7	28	2	24	8	0.3	3.9	0.65	96.3	85.1312	52.3462
2015	7	28	2	34	8	0.3	3.9	0.69	97.3	85.1312	55.5187
2015	7	28	2	44	8	0.3	3.9	0.66	96.3	85.1312	52.8749
2015	7	28	2	54	8	0.3	3.9	0.68	98.3	85.1312	54.1968
2015	7	28	3	4	8	0.3	3.9	0.66	94.9	85.1312	52.8749
2015	7	28	3	14	8	0.3	3.9	0.66	97.4	85.1312	53.1393
2015	7	28	3	24	8	0.3	3.9	0.67	95.6	85.1312	53.9324
2015	7	28	3	34	8	0.3	3.9	0.71	92.7	85.1312	56.8406
2015	7	28	3	44	8	0.3	3.9	0.69	96	85.1312	55.5187
2015	7	28	3	54	8	0.3	3.9	0.68	97.2	85.1312	54.1968
2015	7	28	4	4	8	0.3	3.9	0.67	97.3	85.1312	53.9325
2015	7	28	4	14	8	0.3	3.9	0.68	94.4	85.1312	54.4612
2015	7	28	4	24	8	0.3	3.9	0.67	95.9	85.1312	53.4037
2015	7	28	4	34	8	0.3	3.9	0.7	95.7	85.1312	56.0475
2015	7	28	4	44	8	0.3	3.9	0.69	98.7	85.1312	54.99
2015	7	28	4	54	8	0.3	3.9	0.68	95.8	85.1312	54.4613
2015	7	28	5	4	8	0.3	3.9	0.69	96.8	85.1312	55.5188
2015	7	28	5	14	8	0.3	3.9	0.68	95.6	85.1312	54.1969
2015	7	28	5	24	8	0.3	3.9	0.69	95.7	85.1312	55.2544
2015	7	28	5	34	8	0.3	3.9	0.74	98.9	85.1312	58.9557
2015	7	28	5	44	8	0.3	3.9	0.64	97	85.1312	51.5532
2015	7	28	5	54	8	0.3	3.9	0.69	97.9	85.1312	54.9901
2015	7	28	6	4	8	0.3	3.9	0.69	97.1	85.1312	55.2545
2015	7	28	6	14	8	0.3	3.9	0.7	96.7	85.1312	56.312
2015	7	28	6	24	8	0.3	3.9	0.68	100	85.1312	53.9326
2015	7	28	6	34	8	0.3	3.9	0.69	96.5	85.1312	55.5189
2015	7	28	6	44	8	0.3	3.9	0.66	97.4	85.1312	52.8751
2015	7	28	6	54	8	0.3	3.9	0.69	96.8	85.1312	55.2545
2015	7	28	7	4	8	0.3	3.9	0.69	96.8	85.1312	55.5189
2015	7	28	7	14	8	0.3	3.9	0.73	96.2	85.1312	58.4271
2015	7	28	7	24	8	0.3	3.9	0.71	97.5	85.1312	56.5764
2015	7	28	7	34	8	0.3	3.9	0.7	94.9	85.1312	56.0477
2015	7	28	7	44	8	0.3	3.9	0.68	97.2	85.0656	54.4179
2015	7	28	7	54	8	0.3	3.9	0.72	96.1	85.1312	57.3696
2015	7	28	8	4	8	0.3	3.9	0.68	96.1	85.0656	54.1537
2015	7	28	8	14	8	0.3	3.9	0.66	96.3	85.0656	52.5687
2015	7	28	8	24	8	0.3	3.9	0.69	94.6	85.0656	55.4745
2015	7	28	8	34	8	0.3	3.9	0.69	95.4	85.1312	55.519
2015	7	28	8	44	8	0.3	3.9	0.7	98.4	85.1312	55.519
2015	7	28	8	54	8	0.3	3.9	0.68	97	85.0656	54.1537
2015	7	28	9	4	8	0.3	3.9	0.71	92.6	85.0656	57.3237
2015	7	28	9	14	8	0.3	3.9	0.69	96.8	85.0656	55.4745
2015	7	28	9	24	8	0.3	3.9	0.69	97.1	85.0656	55.2104
2015	7	28	9	34	8	0.3	3.9	0.69	98.5	85.0656	54.9462
2015	7	28	9	44	8	0.3	3.9	0.66	97.4	85	53.0545
2015	7	28	9	54	8	0.3	3.9	0.69	98.2	85.0656	54.682

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	28	10	4	8	0.3	3.9	0.68	97.2	85	54.3743
2015	7	28	10	14	8	0.3	3.9	0.7	95.1	85.0656	55.7387
2015	7	28	10	24	8	0.3	3.9	0.69	97.9	85	54.9022
2015	7	28	10	34	8	0.3	3.9	0.69	97.9	85	54.9021
2015	7	28	10	44	8	0.3	3.9	0.68	94.4	84.9344	54.8581
2015	7	28	10	54	8	0.3	3.9	0.68	100	84.8688	54.0235
2015	7	28	11	4	8	0.3	3.9	0.65	98.1	84.8032	51.8736
2015	7	28	11	14	8	0.3	3.9	0.69	98.2	84.8032	55.0334
2015	7	28	11	24	8	0.3	3.9	0.69	93.5	84.7375	55.2523
2015	7	28	11	34	8	0.3	3.9	0.68	97	84.7375	53.9368
2015	7	28	11	44	8	0.3	3.9	0.69	95.5	84.7375	54.7261
2015	7	28	11	54	8	0.3	3.9	0.64	98.2	84.7375	51.0426
2015	7	28	12	4	8	0.3	3.9	0.7	97.3	84.6719	55.4708
2015	7	28	12	14	8	0.3	3.9	0.69	94.9	84.6719	55.2079
2015	7	28	12	24	8	0.3	3.9	0.67	96.2	84.6719	53.3676
2015	7	28	12	34	8	0.3	3.9	0.7	100.3	84.6719	55.2078
2015	7	28	12	44	8	0.3	3.9	0.7	102.8	84.6719	54.4191
2015	7	28	12	54	8	0.3	3.9	0.69	101.8	84.6719	53.8933
2015	7	28	13	4	8	0.3	3.9	0.71	98.5	84.6063	56.4768
2015	7	28	13	14	8	0.3	3.9	0.69	99.1	84.6719	54.4191
2015	7	28	13	24	8	0.3	3.9	0.7	98.4	84.6719	55.2078
2015	7	28	13	34	8	0.3	3.9	0.69	103.6	84.6063	53.3246
2015	7	28	13	44	8	0.3	3.9	0.71	98.2	84.6063	56.4768
2015	7	28	13	54	8	0.3	3.9	0.68	101.5	84.6063	53.0619
2015	7	28	14	4	8	0.3	3.9	0.71	99.6	84.6063	55.6887
2015	7	28	14	14	8	0.3	3.9	0.71	102.4	84.6063	55.1634
2015	7	28	14	24	8	0.3	3.9	0.7	100.5	84.6063	55.426
2015	7	28	14	34	8	0.3	3.9	0.71	96.9	84.6063	56.2141
2015	7	28	14	44	8	0.3	3.9	0.68	103.8	84.5407	52.4942
2015	7	28	14	54	8	0.3	3.9	0.72	100.3	84.5407	56.4313
2015	7	28	15	4	8	0.3	3.9	0.7	100.5	84.5407	55.3814
2015	7	28	15	14	8	0.3	3.9	0.72	97.9	84.5407	56.9563
2015	7	28	15	24	8	0.3	3.9	0.68	98.6	84.5407	54.0691
2015	7	28	15	34	8	0.3	3.9	0.67	100.2	84.5407	52.4943
2015	7	28	15	44	8	0.3	3.9	0.69	100.1	84.5407	54.594
2015	7	28	15	54	8	0.3	3.9	0.66	100	84.5407	52.2318
2015	7	28	16	4	8	0.3	3.9	0.69	99.1	84.5407	54.3316
2015	7	28	16	14	8	0.3	3.9	0.7	97.6	84.5407	55.119
2015	7	28	16	24	8	0.3	3.9	0.67	98.2	84.5407	52.7568
2015	7	28	16	34	8	0.3	3.9	0.71	98.5	84.5407	56.4314
2015	7	28	16	44	8	0.3	3.9	0.72	100.4	84.4751	56.9104
2015	7	28	16	54	8	0.3	3.9	0.73	97.8	84.4751	57.4349
2015	7	28	17	4	8	0.3	3.9	0.7	99.7	84.5407	55.119
2015	7	28	17	14	8	0.3	3.9	0.72	100.8	84.4751	56.3859
2015	7	28	17	24	8	0.3	3.9	0.71	98.5	84.4751	55.8614
2015	7	28	17	34	8	0.3	3.9	0.69	96.3	84.4751	55.0746
2015	7	28	17	44	8	0.3	3.9	0.71	97.1	84.4751	56.6482

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	28	17	54	8	0.3	3.9	0.68	98	84.4751	54.0256
2015	7	28	18	4	8	0.3	3.9	0.68	97.2	84.4751	53.7633
2015	7	28	18	14	8	0.3	3.9	0.67	99.4	84.4751	52.452
2015	7	28	18	24	8	0.3	3.9	0.66	96	84.4751	52.7143
2015	7	28	18	34	8	0.3	3.9	0.69	97.3	84.4751	55.0746
2015	7	28	18	44	8	0.3	3.9	0.74	97.7	84.4751	58.484
2015	7	28	18	54	8	0.3	3.9	0.69	97.7	84.5407	54.3316
2015	7	28	19	4	8	0.3	3.9	0.69	96.3	84.4751	55.0746
2015	7	28	19	14	8	0.3	3.9	0.7	97.5	84.4751	55.5991
2015	7	28	19	24	8	0.3	3.9	0.65	96.3	84.5407	51.9693
2015	7	28	19	34	8	0.3	3.9	0.66	96	84.5407	52.4943
2015	7	28	19	44	8	0.3	3.9	0.68	96.7	84.5407	53.8066
2015	7	28	19	54	8	0.3	3.9	0.72	98.2	84.5407	56.6938
2015	7	28	20	4	8	0.3	3.9	0.67	96.7	84.5407	53.2817
2015	7	28	20	14	8	0.3	3.9	0.63	99.3	84.5407	49.8695
2015	7	28	20	24	8	0.3	3.9	0.67	97.3	84.5407	53.5441
2015	7	28	20	34	8	0.3	3.9	0.68	95.8	84.5407	54.3315
2015	7	28	20	44	8	0.3	3.9	0.68	96.4	84.5407	54.069
2015	7	28	20	54	8	0.3	3.9	0.65	94	84.5407	51.9693
2015	7	28	21	4	8	0.3	3.9	0.67	96.7	84.5407	53.2816
2015	7	28	21	14	8	0.3	3.9	0.66	94.9	84.5407	52.4942
2015	7	28	21	24	8	0.3	3.9	0.67	95.9	84.5407	53.5441
2015	7	28	21	34	8	0.3	3.9	0.68	98.6	84.5407	53.8065
2015	7	28	21	44	8	0.3	3.9	0.68	99.5	84.5407	53.2816
2015	7	28	21	54	8	0.3	3.9	0.66	95.4	84.5407	52.4942
2015	7	28	22	4	8	0.3	3.9	0.66	95.4	84.5407	52.4942
2015	7	28	22	14	8	0.3	3.9	0.7	95.4	84.6063	55.426
2015	7	28	22	24	8	0.3	3.9	0.68	97.2	84.5407	54.069
2015	7	28	22	34	8	0.3	3.9	0.68	97.5	84.6063	53.8499
2015	7	28	22	44	8	0.3	3.9	0.7	98.3	84.6063	55.6887
2015	7	28	22	54	8	0.3	3.9	0.72	96.1	84.6063	57.0021
2015	7	28	23	4	8	0.3	3.9	0.67	96.4	84.6063	53.5872
2015	7	28	23	14	8	0.3	3.9	0.69	97.9	84.6063	54.6379
2015	7	28	23	24	8	0.3	3.9	0.67	97.3	84.6063	53.3245
2015	7	28	23	34	8	0.3	3.9	0.68	98.4	84.6063	53.5872
2015	7	28	23	44	8	0.3	3.9	0.68	96.3	84.6063	54.3752
2015	7	28	23	54	8	0.3	3.9	0.69	97.9	84.6063	54.6379
2015	7	29	0	4	8	0.3	3.9	0.71	96.9	84.6063	56.214
2015	7	29	0	14	8	0.3	3.9	0.7	97.3	84.6063	55.426
2015	7	29	0	24	8	0.3	3.9	0.66	97.4	84.6063	52.5365
2015	7	29	0	34	8	0.3	3.9	0.68	94.4	84.6063	54.6379
2015	7	29	0	44	8	0.3	3.9	0.67	99.9	84.6063	52.7992
2015	7	29	0	54	8	0.3	3.9	0.7	96.4	84.6063	55.9514
2015	7	29	1	4	8	0.3	3.9	0.73	97.8	84.6063	57.5275
2015	7	29	1	14	8	0.3	3.9	0.67	99.6	84.6063	52.5365
2015	7	29	1	24	8	0.3	3.9	0.65	96.1	84.6063	51.4858
2015	7	29	1	34	8	0.3	3.9	0.67	97.6	84.6719	53.3675

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	29	1	44	8	0.3	3.9	0.68	96.1	84.6063	54.1126
2015	7	29	1	54	8	0.3	3.9	0.68	97.2	84.6719	54.4191
2015	7	29	2	4	8	0.3	3.9	0.67	95.6	84.6719	53.6304
2015	7	29	2	14	8	0.3	3.9	0.69	94.9	84.6719	55.2078
2015	7	29	2	24	8	0.3	3.9	0.67	95.3	84.6719	53.3676
2015	7	29	2	34	8	0.3	3.9	0.65	97.8	84.6719	51.5273
2015	7	29	2	44	8	0.3	3.9	0.68	97	84.6719	53.8934
2015	7	29	2	54	8	0.3	3.9	0.7	95.9	84.6719	55.9966
2015	7	29	3	4	8	0.3	3.9	0.64	95.3	84.6719	51.0016
2015	7	29	3	14	8	0.3	3.9	0.69	96.9	84.6719	54.6821
2015	7	29	3	24	8	0.3	3.9	0.69	94.9	84.6719	55.2079
2015	7	29	3	34	8	0.3	3.9	0.67	94.7	84.6719	53.8935
2015	7	29	3	44	8	0.3	3.9	0.7	98.1	84.6719	55.208
2015	7	29	3	54	8	0.3	3.9	0.71	96.6	84.6719	56.7853
2015	7	29	4	4	8	0.3	3.9	0.68	95.6	84.6719	53.8935
2015	7	29	4	14	8	0.3	3.9	0.68	97.8	84.6719	53.6306
2015	7	29	4	24	8	0.3	3.9	0.65	96.4	84.6719	51.5275
2015	7	29	4	34	8	0.3	3.9	0.67	98.7	84.6719	53.3678
2015	7	29	4	44	8	0.3	3.9	0.68	98.3	84.6719	53.8936
2015	7	29	4	54	8	0.3	3.9	0.67	97	84.6719	53.6307
2015	7	29	5	4	8	0.3	3.9	0.7	96.7	84.6719	55.9968
2015	7	29	5	14	8	0.3	3.9	0.67	95.1	84.6719	53.1049
2015	7	29	5	24	8	0.3	3.9	0.7	97.6	84.6719	55.2081
2015	7	29	5	34	8	0.3	3.9	0.68	93.6	84.7375	54.4632
2015	7	29	5	44	8	0.3	3.9	0.68	98.6	84.7375	53.937
2015	7	29	5	54	8	0.3	3.9	0.7	98.8	84.7375	55.7788
2015	7	29	6	4	8	0.3	3.9	0.68	95.3	84.7375	54.2002
2015	7	29	6	14	8	0.3	3.9	0.66	96	84.8032	52.9271
2015	7	29	6	24	8	0.3	3.9	0.71	99	84.8032	56.3503
2015	7	29	6	34	8	0.3	3.9	0.68	98.6	84.8688	54.0238
2015	7	29	6	44	8	0.3	3.9	0.66	97.1	84.8688	52.7062
2015	7	29	6	54	8	0.3	3.9	0.72	97.4	84.8688	57.1862
2015	7	29	7	4	8	0.3	3.9	0.68	98.3	84.9344	54.0672
2015	7	29	7	14	8	0.3	3.9	0.69	94.4	84.9344	55.3859
2015	7	29	7	24	8	0.3	3.9	0.7	98.4	84.9344	55.6497
2015	7	29	7	34	8	0.3	3.9	0.68	98.9	84.9344	53.8035
2015	7	29	7	44	8	0.3	3.9	0.69	97.4	84.8688	55.078
2015	7	29	7	54	8	0.3	3.9	0.67	96.2	84.8688	53.7603
2015	7	29	8	4	8	0.3	3.9	0.67	94.8	84.8688	53.4968
2015	7	29	8	14	8	0.3	3.9	0.66	98	84.8032	52.4006
2015	7	29	8	24	8	0.3	3.9	0.69	95.7	84.8032	55.0338
2015	7	29	8	34	8	0.3	3.9	0.69	97.7	84.8032	54.5071
2015	7	29	8	44	8	0.3	3.9	0.68	97.5	84.7375	53.674
2015	7	29	8	54	8	0.3	3.9	0.68	98.6	84.6719	53.6308
2015	7	29	9	4	8	0.3	3.9	0.68	96.6	84.6719	54.1566
2015	7	29	9	14	8	0.3	3.9	0.7	98.3	84.6719	55.734
2015	7	29	9	24	8	0.3	3.9	0.69	96.3	84.6719	54.9453

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	29	9	34	8	0.3	3.9	0.7	98.9	84.6719	55.2082
2015	7	29	9	44	8	0.3	3.9	0.7	99.2	84.6719	55.4711
2015	7	29	9	54	8	0.3	3.9	0.7	98.1	84.6719	55.2081
2015	7	29	10	4	8	0.3	3.9	0.68	98	84.6719	54.1566
2015	7	29	10	14	8	0.3	3.9	0.69	98.4	84.6719	54.9452
2015	7	29	10	24	8	0.3	3.9	0.68	97.2	84.6063	53.8503
2015	7	29	10	34	8	0.3	3.9	0.69	97.9	84.6719	54.9452
2015	7	29	10	44	8	0.3	3.9	0.68	98.9	84.6063	53.5876
2015	7	29	10	54	8	0.3	3.9	0.7	98.6	84.6063	55.4263
2015	7	29	11	4	8	0.3	3.9	0.71	99.6	84.6063	55.9517
2015	7	29	11	14	8	0.3	3.9	0.72	99.4	84.6063	57.0024
2015	7	29	11	24	8	0.3	3.9	0.7	103.8	84.6063	54.6382
2015	7	29	11	34	8	0.3	3.9	0.69	101	84.6063	54.1129
2015	7	29	11	44	8	0.3	3.9	0.7	101.3	84.5407	55.1192
2015	7	29	11	54	8	0.3	3.9	0.72	96.8	84.5407	56.9565
2015	7	29	12	4	8	0.3	3.9	0.68	98.6	84.5407	53.5443
2015	7	29	12	14	8	0.3	3.9	0.7	101.8	84.5407	55.1191
2015	7	29	12	24	8	0.3	3.9	0.66	96.6	84.5407	52.2319
2015	7	29	12	34	8	0.3	3.9	0.7	100.8	84.5407	54.8566
2015	7	29	12	44	8	0.3	3.9	0.67	97.3	84.5407	53.5443
2015	7	29	12	54	8	0.3	3.9	0.68	100.8	84.5407	53.8067
2015	7	29	13	4	8	0.3	3.9	0.71	104.7	84.5407	54.8566
2015	7	29	13	14	8	0.3	3.9	0.67	99	84.5407	53.2818
2015	7	29	13	24	8	0.3	3.9	0.7	103.3	84.5407	54.5941
2015	7	29	13	34	8	0.3	3.9	0.67	103.2	84.5407	52.4943
2015	7	29	13	44	8	0.3	3.9	0.69	105.1	84.5407	53.5442
2015	7	29	13	54	8	0.3	3.9	0.69	101.6	84.4751	53.7633
2015	7	29	14	4	8	0.3	3.9	0.67	100.2	84.5407	52.4943
2015	7	29	14	14	8	0.3	3.9	0.67	101.1	84.4751	52.1898
2015	7	29	14	24	8	0.3	3.9	0.67	103.3	84.4751	52.1898
2015	7	29	14	34	8	0.3	3.9	0.71	101.2	84.4751	55.8614
2015	7	29	14	44	8	0.3	3.9	0.69	101.7	84.4751	54.2878
2015	7	29	14	54	8	0.3	3.9	0.69	101	84.4751	53.7633
2015	7	29	15	4	8	0.3	3.9	0.71	101.8	84.4751	55.3369
2015	7	29	15	14	8	0.3	3.9	0.71	98.2	84.4751	56.1237
2015	7	29	15	24	8	0.3	3.9	0.68	97.5	84.4751	53.7633
2015	7	29	15	34	8	0.3	3.9	0.7	101	84.4095	55.0302
2015	7	29	15	44	8	0.3	3.9	0.69	102.9	84.4095	53.72
2015	7	29	15	54	8	0.3	3.9	0.66	100.5	84.4095	52.1477
2015	7	29	16	4	8	0.3	3.9	0.67	101.1	84.4095	52.1477
2015	7	29	16	14	8	0.3	3.9	0.7	101.6	84.4095	54.7682
2015	7	29	16	24	8	0.3	3.9	0.73	98.6	84.4095	57.3887
2015	7	29	16	34	8	0.3	3.9	0.67	99	84.2782	53.11
2015	7	29	16	44	8	0.3	3.9	0.64	103	84.3438	50.0109
2015	7	29	16	54	8	0.3	3.9	0.7	97.8	84.3438	55.2477
2015	7	29	17	4	8	0.3	3.9	0.73	99	84.2782	57.5577
2015	7	29	17	14	8	0.3	3.9	0.7	99.5	84.4095	55.0303

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	29	17	24	8	0.3	3.9	0.7	101.3	84.4095	55.0303
2015	7	29	17	34	8	0.3	3.9	0.71	99.2	84.3438	56.295
2015	7	29	17	44	8	0.3	3.9	0.71	99.1	84.4095	55.8164
2015	7	29	17	54	8	0.3	3.9	0.69	99.8	84.3438	54.4622
2015	7	29	18	4	8	0.3	3.9	0.71	100.6	84.3438	55.7714
2015	7	29	18	14	8	0.3	3.9	0.69	95.4	84.4095	55.0303
2015	7	29	18	24	8	0.3	3.9	0.72	99.5	84.4095	56.3405
2015	7	29	18	34	8	0.3	3.9	0.71	98	84.3438	55.7714
2015	7	29	18	44	8	0.3	3.9	0.69	99	84.3438	54.724
2015	7	29	18	54	8	0.3	3.9	0.71	98.2	84.3438	56.0332
2015	7	29	19	4	8	0.3	3.9	0.69	96.5	84.3438	54.9858
2015	7	29	19	14	8	0.3	3.9	0.68	99.7	84.4095	53.72
2015	7	29	19	24	8	0.3	3.9	0.71	99.9	84.4095	55.8164
2015	7	29	19	34	8	0.3	3.9	0.69	97.6	84.4095	54.7682
2015	7	29	19	44	8	0.3	3.9	0.69	95.2	84.4095	54.5061
2015	7	29	19	54	8	0.3	3.9	0.68	100.8	84.4095	53.72
2015	7	29	20	4	8	0.3	3.9	0.69	98.4	84.4095	54.7681
2015	7	29	20	14	8	0.3	3.9	0.67	100.1	84.4095	52.9338
2015	7	29	20	24	8	0.3	3.9	0.66	95.7	84.4095	52.4097
2015	7	29	20	34	8	0.3	3.9	0.72	95.8	84.4095	57.1265
2015	7	29	20	44	8	0.3	3.9	0.67	99	84.4095	53.1958
2015	7	29	20	54	8	0.3	3.9	0.68	97.5	84.4095	53.7199
2015	7	29	21	4	8	0.3	3.9	0.68	97.8	84.4751	53.7632
2015	7	29	21	14	8	0.3	3.9	0.67	96.5	84.4095	52.9337
2015	7	29	21	24	8	0.3	3.9	0.66	97.1	84.4095	52.4096
2015	7	29	21	34	8	0.3	3.9	0.67	95.9	84.4095	53.4578
2015	7	29	21	44	8	0.3	3.9	0.67	97.3	84.4751	53.501
2015	7	29	21	54	8	0.3	3.9	0.7	98.4	84.4095	55.2921
2015	7	29	22	4	8	0.3	3.9	0.67	95.6	84.4095	53.1957
2015	7	29	22	14	8	0.3	3.9	0.68	96.1	84.4751	53.7632
2015	7	29	22	24	8	0.3	3.9	0.68	94.4	84.4095	54.2439
2015	7	29	22	34	8	0.3	3.9	0.71	95.6	84.4751	56.1235
2015	7	29	22	44	8	0.3	3.9	0.71	96.1	84.4751	56.648
2015	7	29	22	54	8	0.3	3.9	0.68	98.8	84.4751	54.0254
2015	7	29	23	4	8	0.3	3.9	0.66	97.4	84.5407	52.7566
2015	7	29	23	14	8	0.3	3.9	0.68	98.3	84.5407	53.8065
2015	7	29	23	24	8	0.3	3.9	0.66	96	84.5407	52.7566
2015	7	29	23	34	8	0.3	3.9	0.67	97.3	84.4751	53.5009
2015	7	29	23	44	8	0.3	3.9	0.71	98.2	84.5407	56.1687
2015	7	29	23	54	8	0.3	3.9	0.7	97.6	84.5407	55.3813
2015	7	30	0	4	8	0.3	3.9	0.7	99.2	84.5407	55.3813
2015	7	30	0	14	8	0.3	3.9	0.7	97.5	84.5407	55.6437
2015	7	30	0	24	8	0.3	3.9	0.71	98.2	84.5407	56.1687
2015	7	30	0	34	8	0.3	3.9	0.68	96.7	84.5407	53.8064
2015	7	30	0	44	8	0.3	3.9	0.71	96.9	84.5407	56.1687
2015	7	30	0	54	8	0.3	3.9	0.68	96.9	84.5407	54.0689
2015	7	30	1	4	8	0.3	3.9	0.68	98.4	84.6063	53.5871

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	30	1	14	8	0.3	3.9	0.66	95.7	84.5407	52.7565
2015	7	30	1	24	8	0.3	3.9	0.72	96.6	84.6063	57.0019
2015	7	30	1	34	8	0.3	3.9	0.68	97.5	84.6063	54.1124
2015	7	30	1	44	8	0.3	3.9	0.69	94.9	84.6063	54.9005
2015	7	30	1	54	8	0.3	3.9	0.7	97	84.6063	55.4258
2015	7	30	2	4	8	0.3	3.9	0.71	99.5	84.6063	56.2139
2015	7	30	2	14	8	0.3	3.9	0.7	99.2	84.6063	55.1632
2015	7	30	2	24	8	0.3	3.9	0.7	97.5	84.6063	55.6885
2015	7	30	2	34	8	0.3	3.9	0.7	98.1	84.6063	55.4259
2015	7	30	2	44	8	0.3	3.9	0.69	98.5	84.6063	54.6378
2015	7	30	2	54	8	0.3	3.9	0.68	96.9	84.6063	54.1125
2015	7	30	3	4	8	0.3	3.9	0.68	95	84.6063	54.1125
2015	7	30	3	14	8	0.3	3.9	0.7	96.8	84.6063	55.4259
2015	7	30	3	24	8	0.3	3.9	0.7	99.2	84.6063	55.1632
2015	7	30	3	34	8	0.3	3.9	0.71	98.5	84.6063	55.9513
2015	7	30	3	44	8	0.3	3.9	0.68	97.2	84.6063	54.1125
2015	7	30	3	54	8	0.3	3.9	0.68	98.3	84.6063	54.1125
2015	7	30	4	4	8	0.3	3.9	0.71	99.1	84.6063	55.9513
2015	7	30	4	14	8	0.3	3.9	0.72	98.2	84.6063	56.7393
2015	7	30	4	24	8	0.3	3.9	0.7	97.5	84.6063	55.6886
2015	7	30	4	34	8	0.3	3.9	0.65	96.1	84.6063	51.7484
2015	7	30	4	44	8	0.3	3.9	0.7	98.6	84.6063	55.426
2015	7	30	4	54	8	0.3	3.9	0.68	96.6	84.6063	54.1126
2015	7	30	5	4	8	0.3	3.9	0.65	94.3	84.6063	52.2738
2015	7	30	5	14	8	0.3	3.9	0.68	95.3	84.6063	53.8499
2015	7	30	5	24	8	0.3	3.9	0.67	97.6	84.6719	53.3675
2015	7	30	5	34	8	0.3	3.9	0.69	99.9	84.6063	54.3753
2015	7	30	5	44	8	0.3	3.9	0.69	94.4	84.6719	54.9449
2015	7	30	5	54	8	0.3	3.9	0.68	99.1	84.6063	53.8499
2015	7	30	6	4	8	0.3	3.9	0.68	97	84.6719	53.8933
2015	7	30	6	14	8	0.3	3.9	0.68	97.2	84.6719	53.8933
2015	7	30	6	24	8	0.3	3.9	0.68	96.6	84.6719	54.1562
2015	7	30	6	34	8	0.3	3.9	0.7	94	84.6719	55.7336
2015	7	30	6	44	8	0.3	3.9	0.69	96.3	84.6719	54.9449
2015	7	30	6	54	8	0.3	3.9	0.68	96.6	84.6719	54.1562
2015	7	30	7	4	8	0.3	3.9	0.68	97.2	84.6719	53.8934
2015	7	30	7	14	8	0.3	3.9	0.68	98	84.6719	54.1563
2015	7	30	7	24	8	0.3	3.9	0.7	96.2	84.6719	55.7336
2015	7	30	7	34	8	0.3	3.9	0.7	99.9	84.6719	55.4707
2015	7	30	7	44	8	0.3	3.9	0.7	96.8	84.6719	55.4707
2015	7	30	7	54	8	0.3	3.9	0.7	98.3	84.6719	55.7336
2015	7	30	8	4	8	0.3	3.9	0.7	97.6	84.6719	55.2078
2015	7	30	8	14	8	0.3	3.9	0.7	97.9	84.6719	55.2078
2015	7	30	8	24	8	0.3	3.9	0.67	97.9	84.6719	53.1047
2015	7	30	8	34	8	0.3	3.9	0.69	99.8	84.6719	54.6821
2015	7	30	8	44	8	0.3	3.9	0.7	96.5	84.6719	55.4707
2015	7	30	8	54	8	0.3	3.9	0.7	96.4	84.6719	55.9965

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	30	9	10	21	0.3	3.9	0.67	98.4	84.6719	53.1047
2015	7	30	9	20	21	0.3	3.9	0.69	97.3	84.6719	55.2078
2015	7	30	9	30	21	0.3	3.9	0.7	96.8	84.6719	55.4707
2015	7	30	9	40	21	0.3	3.9	0.67	97.3	84.6719	53.1047
2015	7	30	9	50	21	0.3	3.9	0.71	99	84.6719	56.5223
2015	7	30	10	0	21	0.3	3.9	0.7	97	84.6719	55.7336
2015	7	30	10	10	21	0.3	3.9	0.72	100.7	84.6719	56.7852
2015	7	30	10	20	21	0.3	3.9	0.7	97.8	84.6719	55.4707
2015	7	30	10	30	21	0.3	3.9	0.69	99.9	84.6719	54.4191
2015	7	30	10	40	21	0.3	3.9	0.69	100.6	84.6719	54.682
2015	7	30	10	50	21	0.3	3.9	0.75	99.3	84.6719	59.1511
2015	7	30	11	0	21	0.3	3.9	0.72	96.8	84.6719	57.048
2015	7	30	11	10	21	0.3	3.9	0.67	101.3	84.6719	52.5788
2015	7	30	11	20	21	0.3	3.9	0.67	97.7	84.6719	52.8417
2015	7	30	11	30	21	0.3	3.9	0.66	102.3	84.6719	51.7901
2015	7	30	11	40	21	0.3	3.9	0.71	100.9	84.6719	55.7335
2015	7	30	11	50	21	0.3	3.9	0.74	101.5	84.6063	58.0528
2015	7	30	12	0	21	0.3	3.9	0.69	100.1	84.6719	54.6819
2015	7	30	12	10	21	0.3	3.9	0.72	98.4	84.6063	56.7394
2015	7	30	12	20	21	0.3	3.9	0.71	100.1	84.6063	56.214
2015	7	30	12	30	21	0.3	3.9	0.69	99.9	84.6063	54.1126
2015	7	30	12	40	21	0.3	3.9	0.69	102.9	84.6063	53.8499
2015	7	30	12	50	21	0.3	3.9	0.7	98.4	84.6063	55.426
2015	7	30	13	0	21	0.3	3.9	0.68	100.6	84.6063	53.5872
2015	7	30	13	10	21	0.3	3.9	0.68	98.8	84.6063	54.1126
2015	7	30	13	20	21	0.3	3.9	0.67	99.6	84.6063	52.7991
2015	7	30	13	30	21	0.3	3.9	0.69	102.1	84.6063	54.1125
2015	7	30	13	40	21	0.3	3.9	0.68	98.9	84.6063	53.8498
2015	7	30	13	50	21	0.3	3.9	0.69	100.9	84.6063	54.3752
2015	7	30	14	0	21	0.3	3.9	0.69	100.9	84.6063	54.3752
2015	7	30	14	10	21	0.3	3.9	0.68	99.7	84.6063	53.8498
2015	7	30	14	20	21	0.3	3.9	0.71	98.2	84.6063	56.4766
2015	7	30	14	30	21	0.3	3.9	0.69	101.3	84.6063	54.1125
2015	7	30	14	40	21	0.3	3.9	0.69	97.3	84.6063	55.1632
2015	7	30	14	50	21	0.3	3.9	0.7	100.5	84.6063	55.1632
2015	7	30	15	0	21	0.3	3.9	0.68	97.5	84.6063	54.1125
2015	7	30	15	10	21	0.3	3.9	0.65	96.1	84.6063	52.011
2015	7	30	15	20	21	0.3	3.9	0.7	95.9	84.6063	55.9512
2015	7	30	15	30	21	0.3	3.9	0.68	97.5	84.6063	54.1124
2015	7	30	15	40	21	0.3	3.9	0.68	101.4	84.6063	53.3244
2015	7	30	15	50	21	0.3	3.9	0.66	97.4	84.6063	52.7991
2015	7	30	16	0	21	0.3	3.9	0.68	98.6	84.5407	54.069
2015	7	30	16	10	21	0.3	3.9	0.68	95.8	84.6063	54.3752
2015	7	30	16	20	21	0.3	3.9	0.67	95.4	84.6063	53.0618
2015	7	30	16	30	21	0.3	3.9	0.67	97.9	84.6063	53.0618
2015	7	30	16	40	21	0.3	3.9	0.68	94.4	84.6063	54.6379
2015	7	30	16	50	21	0.3	3.9	0.69	96.6	84.6063	54.6379

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	30	17	0	21	0.3	3.9	0.67	97.6	84.6063	53.3245
2015	7	30	17	10	21	0.3	3.9	0.69	95.5	84.6063	54.9006
2015	7	30	17	20	21	0.3	3.9	0.68	94.4	84.6063	54.3752
2015	7	30	17	30	21	0.3	3.9	0.69	98.2	84.6719	54.419
2015	7	30	17	40	21	0.3	3.9	0.68	94.7	84.6719	54.1561
2015	7	30	17	50	21	0.3	3.9	0.69	97.1	84.6063	54.9006
2015	7	30	18	0	21	0.3	3.9	0.67	97.3	84.6719	53.6303
2015	7	30	18	10	21	0.3	3.9	0.7	96	84.6719	55.4706
2015	7	30	18	20	21	0.3	3.9	0.68	97.2	84.6719	54.1561
2015	7	30	18	30	21	0.3	3.9	0.7	96.8	84.6719	55.4706
2015	7	30	18	40	21	0.3	3.9	0.71	95.6	84.6719	56.2593
2015	7	30	18	50	21	0.3	3.9	0.7	98.4	84.6719	55.2077
2015	7	30	19	0	21	0.3	3.9	0.69	97.1	84.6719	54.9448
2015	7	30	19	10	21	0.3	3.9	0.68	97.5	84.6719	53.8932
2015	7	30	19	20	21	0.3	3.9	0.68	97.8	84.6719	53.6303
2015	7	30	19	30	21	0.3	3.9	0.68	97.2	84.7375	53.9366
2015	7	30	19	40	21	0.3	3.9	0.66	97.1	84.7375	52.8842
2015	7	30	19	50	21	0.3	3.9	0.67	95.6	84.7375	53.4104
2015	7	30	20	0	21	0.3	3.9	0.7	98.4	84.7375	55.5152
2015	7	30	20	10	21	0.3	3.9	0.65	94.4	84.6719	51.7901
2015	7	30	20	20	21	0.3	3.9	0.7	98.4	84.7375	55.5152
2015	7	30	20	30	21	0.3	3.9	0.68	96.9	84.7375	54.4628
2015	7	30	20	40	21	0.3	3.9	0.66	97.4	84.7375	52.8842
2015	7	30	20	50	21	0.3	3.9	0.71	96.6	84.7375	56.5676
2015	7	30	21	0	21	0.3	3.9	0.67	97.3	84.7375	53.6735
2015	7	30	21	10	21	0.3	3.9	0.71	96.1	84.7375	56.3045
2015	7	30	21	20	21	0.3	3.9	0.69	95.2	84.7375	54.7259
2015	7	30	21	30	21	0.3	3.9	0.68	98.1	84.7375	53.9365
2015	7	30	21	40	21	0.3	3.9	0.69	97.9	84.7375	54.7259
2015	7	30	21	50	21	0.3	3.9	0.66	96.2	84.8032	52.9266
2015	7	30	22	0	21	0.3	3.9	0.69	94.1	84.8032	55.0332
2015	7	30	22	10	21	0.3	3.9	0.68	96.7	84.8032	53.9799
2015	7	30	22	20	21	0.3	3.9	0.7	95.4	84.8032	55.5598
2015	7	30	22	30	21	0.3	3.9	0.69	98.4	84.8032	55.0331
2015	7	30	22	40	21	0.3	3.9	0.68	97.2	84.8032	53.9799
2015	7	30	22	50	21	0.3	3.9	0.67	97.3	84.8032	53.1899
2015	7	30	23	0	21	0.3	3.9	0.68	97.5	84.8032	53.9799
2015	7	30	23	10	21	0.3	3.9	0.71	99.1	84.8032	56.0864
2015	7	30	23	20	21	0.3	3.9	0.7	96.2	84.8688	55.8679
2015	7	30	23	30	21	0.3	3.9	0.68	97.5	84.8688	54.2868
2015	7	30	23	40	21	0.3	3.9	0.67	95.6	84.8688	53.4962
2015	7	30	23	50	21	0.3	3.9	0.66	96.8	84.9344	53.0116
2015	7	31	0	0	21	0.3	3.9	0.68	97.5	84.9344	54.3303
2015	7	31	0	10	21	0.3	3.9	0.69	96.3	85	55.1657
2015	7	31	0	20	21	0.3	3.9	0.7	98.3	85	55.9576
2015	7	31	0	30	21	0.3	3.9	0.7	98.1	85	55.6936
2015	7	31	0	40	21	0.3	3.9	0.68	96.4	85.0656	54.4175

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	31	0	50	21	0.3	3.9	0.71	96.7	85.0656	56.5308
2015	7	31	1	0	21	0.3	3.9	0.7	97.2	85.0656	56.2666
2015	7	31	1	10	21	0.3	3.9	0.69	98.2	85.0656	54.6816
2015	7	31	1	20	21	0.3	3.9	0.71	96.7	85.1312	56.576
2015	7	31	1	30	21	0.3	3.9	0.68	96.9	85.1312	54.7254
2015	7	31	1	40	21	0.3	3.9	0.7	100	85.1312	55.5185
2015	7	31	1	50	21	0.3	3.9	0.7	98.9	85.1312	55.7829
2015	7	31	2	0	21	0.3	3.9	0.73	97.5	85.1312	58.1623
2015	7	31	2	10	21	0.3	3.9	0.72	97.9	85.1312	57.1048
2015	7	31	2	20	21	0.3	3.9	0.72	94.5	85.1312	57.6336
2015	7	31	2	30	21	0.3	3.9	0.67	98.4	85.1969	53.4463
2015	7	31	2	40	21	0.3	3.9	0.69	97.1	85.1969	55.2984
2015	7	31	2	50	21	0.3	3.9	0.65	94.7	85.1969	51.8588
2015	7	31	3	0	21	0.3	3.9	0.68	95.5	85.1969	54.7692
2015	7	31	3	10	21	0.3	3.9	0.66	97.7	85.1969	52.9171
2015	7	31	3	20	21	0.3	3.9	0.67	95.3	85.1969	53.7109
2015	7	31	3	30	21	0.3	3.9	0.65	96.3	85.1969	52.388
2015	7	31	3	40	21	0.3	3.9	0.68	95.5	85.1969	54.7692
2015	7	31	3	50	21	0.3	3.9	0.71	94.5	85.1969	56.8859
2015	7	31	4	0	21	0.3	3.9	0.66	95.7	85.1969	52.6526
2015	7	31	4	10	21	0.3	3.9	0.67	101	85.1969	53.1817
2015	7	31	4	20	21	0.3	3.9	0.71	96.7	85.1969	56.6213
2015	7	31	4	30	21	0.3	3.9	0.68	97.2	85.2625	54.5482
2015	7	31	4	40	21	0.3	3.9	0.7	98.1	85.2625	56.137
2015	7	31	4	50	21	0.3	3.9	0.67	96.5	85.1969	53.4463
2015	7	31	5	0	21	0.3	3.9	0.7	96.8	85.2625	55.8722
2015	7	31	5	10	21	0.3	3.9	0.68	96.9	85.2625	54.5483
2015	7	31	5	20	21	0.3	3.9	0.69	97.7	85.2625	54.813
2015	7	31	5	30	21	0.3	3.9	0.7	95.4	85.2625	56.4018
2015	7	31	5	40	21	0.3	3.9	0.7	97	85.2625	56.137
2015	7	31	5	50	21	0.3	3.9	0.67	97.9	85.2625	53.2243
2015	7	31	6	0	21	0.3	3.9	0.68	98	85.2625	54.5483
2015	7	31	6	10	21	0.3	3.9	0.69	97.6	85.2625	55.3426
2015	7	31	6	20	21	0.3	3.9	0.71	98.2	85.2625	56.6666
2015	7	31	6	30	21	0.3	3.9	0.68	98.1	85.3281	54.3268
2015	7	31	6	40	21	0.3	3.9	0.69	95.5	85.3281	55.1218
2015	7	31	6	50	21	0.3	3.9	0.69	96.5	85.3281	55.6519
2015	7	31	7	0	21	0.3	3.9	0.68	97.2	85.3281	54.3268
2015	7	31	7	10	21	0.3	3.9	0.71	98.5	85.3281	56.9769
2015	7	31	7	20	21	0.3	3.9	0.7	96.8	85.3281	55.9169
2015	7	31	7	30	21	0.3	3.9	0.69	97.3	85.3281	55.6519
2015	7	31	7	40	21	0.3	3.9	0.69	97.7	85.3281	54.8568
2015	7	31	7	50	21	0.3	3.9	0.69	97.1	85.3281	55.3869
2015	7	31	8	0	21	0.3	3.9	0.68	98.6	85.3281	54.5918
2015	7	31	8	10	21	0.3	3.9	0.68	96.9	85.3281	54.5918
2015	7	31	8	20	21	0.3	3.9	0.69	96.3	85.3281	55.3868
2015	7	31	8	30	21	0.3	3.9	0.69	94.6	85.3281	55.9169

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	31	8	40	21	0.3	3.9	0.69	98.5	85.3281	55.1218
2015	7	31	8	50	21	0.3	3.9	0.72	95.2	85.3281	57.7719
2015	7	31	9	0	21	0.3	3.9	0.7	97.3	85.3281	55.9169
2015	7	31	9	10	21	0.3	3.9	0.73	97.5	85.3281	58.3019
2015	7	31	9	20	21	0.3	3.9	0.7	95.1	85.3281	55.9168
2015	7	31	9	30	21	0.3	3.9	0.72	96.8	85.3281	57.5069
2015	7	31	9	40	21	0.3	3.9	0.69	96.9	85.3281	55.1218
2015	7	31	9	50	21	0.3	3.9	0.74	98.9	85.3281	59.0969
2015	7	31	10	0	21	0.3	3.9	0.69	95.2	85.3281	55.1218
2015	7	31	10	10	21	0.3	3.9	0.71	101	85.3281	55.9168
2015	7	31	10	20	21	0.3	3.9	0.7	96.4	85.3281	56.4468
2015	7	31	10	30	21	0.3	3.9	0.71	99.6	85.3281	56.4468
2015	7	31	10	40	21	0.3	3.9	0.71	96.6	85.3281	57.2418
2015	7	31	10	50	21	0.3	3.9	0.69	99.3	85.3281	55.1218
2015	7	31	11	0	21	0.3	3.9	0.71	97.4	85.3281	57.2418
2015	7	31	11	10	21	0.3	3.9	0.7	94.8	85.3281	56.7118
2015	7	31	11	20	21	0.3	3.9	0.67	96.4	85.3281	54.0617
2015	7	31	11	30	21	0.3	3.9	0.69	95.5	85.3281	55.3868
2015	7	31	11	40	21	0.3	3.9	0.71	98.2	85.3281	56.9768
2015	7	31	11	50	21	0.3	3.9	0.68	97.2	85.3281	54.8567
2015	7	31	12	0	21	0.3	3.9	0.68	95.3	85.3281	54.3267
2015	7	31	12	10	21	0.3	3.9	0.69	97.7	85.3281	54.8567
2015	7	31	12	20	21	0.3	3.9	0.71	95.8	85.3281	56.9768
2015	7	31	12	30	21	0.3	3.9	0.67	97.3	85.3281	54.0617
2015	7	31	12	40	21	0.3	3.9	0.71	98.2	85.3281	56.9768
2015	7	31	12	50	21	0.3	3.9	0.71	97.8	85.3281	56.4468
2015	7	31	13	0	21	0.3	3.9	0.7	98.1	85.3281	56.1817
2015	7	31	13	10	21	0.3	3.9	0.67	98.7	85.3281	53.5316
2015	7	31	13	20	21	0.3	3.9	0.71	100.4	85.3281	56.1817
2015	7	31	13	30	21	0.3	3.9	0.7	98.4	85.3281	55.6517
2015	7	31	13	40	21	0.3	3.9	0.71	100.1	85.3281	56.7117
2015	7	31	13	50	21	0.3	3.9	0.72	100.2	85.3281	57.5067
2015	7	31	14	0	21	0.3	3.9	0.7	97.5	85.3281	56.4467
2015	7	31	14	10	21	0.3	3.9	0.69	98.4	85.3281	55.3866
2015	7	31	14	20	21	0.3	3.9	0.69	97.9	85.3281	55.1216
2015	7	31	14	30	21	0.3	3.9	0.73	99.1	85.3281	58.0366
2015	7	31	14	40	21	0.3	3.9	0.68	97.5	85.3281	54.3265
2015	7	31	14	50	21	0.3	3.9	0.67	97	85.3281	54.0615
2015	7	31	15	0	21	0.3	3.9	0.69	96.5	85.3281	55.6515
2015	7	31	15	10	21	0.3	3.9	0.68	96.7	85.2625	54.2831
2015	7	31	15	20	21	0.3	3.9	0.67	97.6	85.2625	53.4887
2015	7	31	15	30	21	0.3	3.9	0.68	99.4	85.2625	54.2831
2015	7	31	15	40	21	0.3	3.9	0.69	98.2	85.2625	54.8127
2015	7	31	15	50	21	0.3	3.9	0.7	95.7	85.2625	56.1367
2015	7	31	16	0	21	0.3	3.9	0.7	100.3	85.1969	55.2981
2015	7	31	16	10	21	0.3	3.9	0.7	98.3	85.2625	56.1367
2015	7	31	16	20	21	0.3	3.9	0.7	102.5	85.1969	54.769

Mazourka (0354)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	31	16	30	21	0.3	3.9	0.69	99.1	85.1969	54.769
2015	7	31	16	40	21	0.3	3.9	0.71	100.6	85.1969	56.621
2015	7	31	16	50	21	0.3	3.9	0.66	98.6	85.1969	52.6523
2015	7	31	17	0	21	0.3	3.9	0.7	96.5	85.1969	56.0919
2015	7	31	17	10	21	0.3	3.9	0.7	94.8	85.1969	56.3565
2015	7	31	17	20	21	0.3	3.9	0.71	98	85.1969	56.3565
2015	7	31	17	30	21	0.3	3.9	0.69	96.8	85.1969	55.5628
2015	7	31	17	40	21	0.3	3.9	0.69	94.4	85.1969	55.5628
2015	7	31	17	50	21	0.3	3.9	0.69	97.3	85.1969	55.5628
2015	7	31	18	0	21	0.3	3.9	0.69	98.2	85.1969	55.2982
2015	7	31	18	10	21	0.3	3.9	0.69	96.8	85.1969	55.2982
2015	7	31	18	20	21	0.3	3.9	0.67	96.7	85.1969	53.7107
2015	7	31	18	30	21	0.3	3.9	0.69	98.5	85.1969	55.0336
2015	7	31	18	40	21	0.3	3.9	0.69	98.5	85.1969	54.769
2015	7	31	18	50	21	0.3	3.9	0.7	95.4	85.1969	56.3565
2015	7	31	19	0	21	0.3	3.9	0.71	96.9	85.1969	56.6211
2015	7	31	19	10	21	0.3	3.9	0.69	95.7	85.1969	55.2982
2015	7	31	19	20	21	0.3	3.9	0.68	97.2	85.1969	54.5044
2015	7	31	19	30	21	0.3	3.9	0.68	97.7	85.1969	54.5044
2015	7	31	19	40	21	0.3	3.9	0.72	96.6	85.1969	57.4148
2015	7	31	19	50	21	0.3	3.9	0.65	96.3	85.1969	52.3877
2015	7	31	20	0	21	0.3	3.9	0.7	97	85.1969	55.8273
2015	7	31	20	10	21	0.3	3.9	0.68	97.8	85.1969	53.9752
2015	7	31	20	20	21	0.3	3.9	0.68	95.5	85.1969	54.769
2015	7	31	20	30	21	0.3	3.9	0.66	99.1	85.2625	52.9592
2015	7	31	20	40	21	0.3	3.9	0.68	97.2	85.2625	54.8128
2015	7	31	20	50	21	0.3	3.9	0.69	96.3	85.2625	55.3424
2015	7	31	21	0	21	0.3	3.9	0.67	96.7	85.2625	53.7536
2015	7	31	21	10	21	0.3	3.9	0.68	98.1	85.2625	54.2832
2015	7	31	21	20	21	0.3	3.9	0.71	96.7	85.2625	56.6663
2015	7	31	21	30	21	0.3	3.9	0.68	97.5	85.2625	54.2831
2015	7	31	21	40	21	0.3	3.9	0.69	98.5	85.2625	54.8127
2015	7	31	21	50	21	0.3	3.9	0.7	95.7	85.2625	55.8719
2015	7	31	22	0	21	0.3	3.9	0.67	97.9	85.2625	53.2239
2015	7	31	22	10	21	0.3	3.9	0.71	98	85.3281	56.4466
2015	7	31	22	20	21	0.3	3.9	0.68	98.9	85.3281	54.3265
2015	7	31	22	30	21	0.3	3.9	0.7	95.7	85.3281	56.1815
2015	7	31	22	40	21	0.3	3.9	0.66	97.4	85.3281	52.7364
2015	7	31	22	50	21	0.3	3.9	0.65	95.8	85.3281	52.4714
2015	7	31	23	0	21	0.3	3.9	0.67	95.9	85.3281	53.5314
2015	7	31	23	10	21	0.3	3.9	0.71	98.5	85.3281	56.4465
2015	7	31	23	20	21	0.3	3.9	0.7	97.3	85.3281	56.1815
2015	7	31	23	30	21	0.3	3.9	0.67	94.5	85.3937	54.1046
2015	7	31	23	40	21	0.3	3.9	0.7	93.8	85.3937	56.2263
2015	7	31	23	50	21	0.3	3.9	0.69	94.9	85.3937	55.4307

Locust Ditch Return

Station 0215

Date	Flow (cfs)
7/1/2015	0
7/2/2015	0
7/3/2015	0
7/4/2015	0
7/5/2015	0
7/6/2015	0
7/7/2015	0
7/8/2015	0
7/9/2015	0
7/10/2015	0
7/11/2015	0
7/12/2015	0
7/13/2015	0
7/14/2015	0
7/15/2015	1.256
7/16/2015	4.761
7/17/2015	7.387
7/18/2015	7.075
7/19/2015	7.349
7/20/2015	7.326
7/21/2015	7.239
7/22/2015	7.624
7/23/2015	8.241
7/24/2015	8.774
7/25/2015	9.01
7/26/2015	9.005
7/27/2015	9.001
7/28/2015	9.024
7/29/2015	9.164
7/30/2015	9.303
7/31/2015	9.449

Locust Ditch Return Gage

DATE	TIME	GAGE
7/1/2015	12:00:00 AM	0.00
7/1/2015	12:15:00 AM	0.00
7/1/2015	12:30:00 AM	0.00
7/1/2015	12:45:00 AM	0.00
7/1/2015	1:00:00 AM	0.00
7/1/2015	1:15:00 AM	0.00
7/1/2015	1:30:00 AM	0.00
7/1/2015	1:45:00 AM	0.00
7/1/2015	2:00:00 AM	0.00
7/1/2015	2:15:00 AM	0.00
7/1/2015	2:30:00 AM	0.00
7/1/2015	2:45:00 AM	0.00
7/1/2015	3:00:00 AM	0.00
7/1/2015	3:15:00 AM	0.00
7/1/2015	3:30:00 AM	0.00
7/1/2015	3:45:00 AM	0.00
7/1/2015	4:00:00 AM	0.00
7/1/2015	4:15:00 AM	0.00
7/1/2015	4:30:00 AM	0.00
7/1/2015	4:45:00 AM	0.00
7/1/2015	5:00:00 AM	0.00
7/1/2015	5:15:00 AM	0.00
7/1/2015	5:30:00 AM	0.00
7/1/2015	5:45:00 AM	0.00
7/1/2015	6:00:00 AM	0.00
7/1/2015	6:15:00 AM	0.00
7/1/2015	6:30:00 AM	0.00
7/1/2015	6:45:00 AM	0.00
7/1/2015	7:00:00 AM	0.00
7/1/2015	7:15:00 AM	0.00
7/1/2015	7:30:00 AM	0.00
7/1/2015	7:45:00 AM	0.00
7/1/2015	8:00:00 AM	0.00
7/1/2015	8:15:00 AM	0.00
7/1/2015	8:30:00 AM	0.00
7/1/2015	8:45:00 AM	0.00
7/1/2015	9:00:00 AM	0.00
7/1/2015	9:15:00 AM	0.00
7/1/2015	9:30:00 AM	0.00
7/1/2015	9:45:00 AM	0.00
7/1/2015	10:00:00 AM	0.00
7/1/2015	10:15:00 AM	0.00
7/1/2015	10:30:00 AM	0.00
7/1/2015	10:45:00 AM	0.00
7/1/2015	11:00:00 AM	0.00
7/1/2015	11:15:00 AM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/1/2015	11:30:00 AM	0.00
7/1/2015	11:45:00 AM	0.00
7/1/2015	12:00:00 PM	0.00
7/1/2015	12:15:00 PM	0.00
7/1/2015	12:30:00 PM	0.00
7/1/2015	12:45:00 PM	0.00
7/1/2015	1:00:00 PM	0.00
7/1/2015	1:15:00 PM	0.00
7/1/2015	1:30:00 PM	0.00
7/1/2015	1:45:00 PM	0.00
7/1/2015	2:00:00 PM	0.00
7/1/2015	2:15:00 PM	0.00
7/1/2015	2:30:00 PM	0.00
7/1/2015	2:45:00 PM	0.00
7/1/2015	3:00:00 PM	0.00
7/1/2015	3:15:00 PM	0.00
7/1/2015	3:30:00 PM	0.00
7/1/2015	3:45:00 PM	0.00
7/1/2015	4:00:00 PM	0.00
7/1/2015	4:15:00 PM	0.00
7/1/2015	4:30:00 PM	0.00
7/1/2015	4:45:00 PM	0.00
7/1/2015	5:00:00 PM	0.00
7/1/2015	5:15:00 PM	0.00
7/1/2015	5:30:00 PM	0.00
7/1/2015	5:45:00 PM	0.00
7/1/2015	6:00:00 PM	0.00
7/1/2015	6:15:00 PM	0.00
7/1/2015	6:30:00 PM	0.00
7/1/2015	6:45:00 PM	0.00
7/1/2015	7:00:00 PM	0.00
7/1/2015	7:15:00 PM	0.00
7/1/2015	7:30:00 PM	0.00
7/1/2015	7:45:00 PM	0.00
7/1/2015	8:00:00 PM	0.00
7/1/2015	8:15:00 PM	0.00
7/1/2015	8:30:00 PM	0.00
7/1/2015	8:45:00 PM	0.00
7/1/2015	9:00:00 PM	0.00
7/1/2015	9:15:00 PM	0.00
7/1/2015	9:30:00 PM	0.00
7/1/2015	9:45:00 PM	0.00
7/1/2015	10:00:00 PM	0.00
7/1/2015	10:15:00 PM	0.00
7/1/2015	10:30:00 PM	0.00
7/1/2015	10:45:00 PM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/1/2015	11:00:00 PM	0.00
7/1/2015	11:15:00 PM	0.00
7/1/2015	11:30:00 PM	0.00
7/1/2015	11:45:00 PM	0.00
7/2/2015	12:00:00 AM	0.00
7/2/2015	12:15:00 AM	0.00
7/2/2015	12:30:00 AM	0.00
7/2/2015	12:45:00 AM	0.00
7/2/2015	1:00:00 AM	0.00
7/2/2015	1:15:00 AM	0.00
7/2/2015	1:30:00 AM	0.00
7/2/2015	1:45:00 AM	0.00
7/2/2015	2:00:00 AM	0.00
7/2/2015	2:15:00 AM	0.00
7/2/2015	2:30:00 AM	0.00
7/2/2015	2:45:00 AM	0.00
7/2/2015	3:00:00 AM	0.00
7/2/2015	3:15:00 AM	0.00
7/2/2015	3:30:00 AM	0.00
7/2/2015	3:45:00 AM	0.00
7/2/2015	4:00:00 AM	0.00
7/2/2015	4:15:00 AM	0.00
7/2/2015	4:30:00 AM	0.00
7/2/2015	4:45:00 AM	0.00
7/2/2015	5:00:00 AM	0.00
7/2/2015	5:15:00 AM	0.00
7/2/2015	5:30:00 AM	0.00
7/2/2015	5:45:00 AM	0.00
7/2/2015	6:00:00 AM	0.00
7/2/2015	6:15:00 AM	0.00
7/2/2015	6:30:00 AM	0.00
7/2/2015	6:45:00 AM	0.00
7/2/2015	7:00:00 AM	0.00
7/2/2015	7:15:00 AM	0.00
7/2/2015	7:30:00 AM	0.00
7/2/2015	7:45:00 AM	0.00
7/2/2015	8:00:00 AM	0.00
7/2/2015	8:15:00 AM	0.00
7/2/2015	8:30:00 AM	0.00
7/2/2015	8:45:00 AM	0.00
7/2/2015	9:00:00 AM	0.00
7/2/2015	9:15:00 AM	0.00
7/2/2015	9:30:00 AM	0.00
7/2/2015	9:45:00 AM	0.00
7/2/2015	10:00:00 AM	0.00
7/2/2015	10:15:00 AM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/2/2015	10:30:00 AM	0.00
7/2/2015	10:45:00 AM	0.00
7/2/2015	11:00:00 AM	0.00
7/2/2015	11:15:00 AM	0.00
7/2/2015	11:30:00 AM	0.00
7/2/2015	11:45:00 AM	0.00
7/2/2015	12:00:00 PM	0.00
7/2/2015	12:15:00 PM	0.00
7/2/2015	12:30:00 PM	0.00
7/2/2015	12:45:00 PM	0.00
7/2/2015	1:00:00 PM	0.00
7/2/2015	1:15:00 PM	0.00
7/2/2015	1:30:00 PM	0.00
7/2/2015	1:45:00 PM	0.00
7/2/2015	2:00:00 PM	0.00
7/2/2015	2:15:00 PM	0.00
7/2/2015	2:30:00 PM	0.00
7/2/2015	2:45:00 PM	0.00
7/2/2015	3:00:00 PM	0.00
7/2/2015	3:15:00 PM	0.00
7/2/2015	3:30:00 PM	0.00
7/2/2015	3:45:00 PM	0.00
7/2/2015	4:00:00 PM	0.00
7/2/2015	4:15:00 PM	0.00
7/2/2015	4:30:00 PM	0.00
7/2/2015	4:45:00 PM	0.00
7/2/2015	5:00:00 PM	0.00
7/2/2015	5:15:00 PM	0.00
7/2/2015	5:30:00 PM	0.00
7/2/2015	5:45:00 PM	0.00
7/2/2015	6:00:00 PM	0.00
7/2/2015	6:15:00 PM	0.00
7/2/2015	6:30:00 PM	0.00
7/2/2015	6:45:00 PM	0.00
7/2/2015	7:00:00 PM	0.00
7/2/2015	7:15:00 PM	0.00
7/2/2015	7:30:00 PM	0.00
7/2/2015	7:45:00 PM	0.00
7/2/2015	8:00:00 PM	0.00
7/2/2015	8:15:00 PM	0.00
7/2/2015	8:30:00 PM	0.00
7/2/2015	8:45:00 PM	0.00
7/2/2015	9:00:00 PM	0.00
7/2/2015	9:15:00 PM	0.00
7/2/2015	9:30:00 PM	0.00
7/2/2015	9:45:00 PM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/2/2015	10:00:00 PM	0.00
7/2/2015	10:15:00 PM	0.00
7/2/2015	10:30:00 PM	0.00
7/2/2015	10:45:00 PM	0.00
7/2/2015	11:00:00 PM	0.00
7/2/2015	11:15:00 PM	0.00
7/2/2015	11:30:00 PM	0.00
7/2/2015	11:45:00 PM	0.00
7/3/2015	12:00:00 AM	0.00
7/3/2015	12:15:00 AM	0.00
7/3/2015	12:30:00 AM	0.00
7/3/2015	12:45:00 AM	0.00
7/3/2015	1:00:00 AM	0.00
7/3/2015	1:15:00 AM	0.00
7/3/2015	1:30:00 AM	0.00
7/3/2015	1:45:00 AM	0.00
7/3/2015	2:00:00 AM	0.00
7/3/2015	2:15:00 AM	0.00
7/3/2015	2:30:00 AM	0.00
7/3/2015	2:45:00 AM	0.00
7/3/2015	3:00:00 AM	0.00
7/3/2015	3:15:00 AM	0.00
7/3/2015	3:30:00 AM	0.00
7/3/2015	3:45:00 AM	0.00
7/3/2015	4:00:00 AM	0.00
7/3/2015	4:15:00 AM	0.00
7/3/2015	4:30:00 AM	0.00
7/3/2015	4:45:00 AM	0.00
7/3/2015	5:00:00 AM	0.00
7/3/2015	5:15:00 AM	0.00
7/3/2015	5:30:00 AM	0.00
7/3/2015	5:45:00 AM	0.00
7/3/2015	6:00:00 AM	0.00
7/3/2015	6:15:00 AM	0.00
7/3/2015	6:30:00 AM	0.00
7/3/2015	6:45:00 AM	0.00
7/3/2015	7:00:00 AM	0.00
7/3/2015	7:15:00 AM	0.00
7/3/2015	7:30:00 AM	0.00
7/3/2015	7:45:00 AM	0.00
7/3/2015	8:00:00 AM	0.00
7/3/2015	8:15:00 AM	0.00
7/3/2015	8:30:00 AM	0.00
7/3/2015	8:45:00 AM	0.00
7/3/2015	9:00:00 AM	0.00
7/3/2015	9:15:00 AM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/3/2015	9:30:00 AM	0.00
7/3/2015	9:45:00 AM	0.00
7/3/2015	10:00:00 AM	0.00
7/3/2015	10:15:00 AM	0.00
7/3/2015	10:30:00 AM	0.00
7/3/2015	10:45:00 AM	0.00
7/3/2015	11:00:00 AM	0.00
7/3/2015	11:15:00 AM	0.00
7/3/2015	11:30:00 AM	0.00
7/3/2015	11:45:00 AM	0.00
7/3/2015	12:00:00 PM	0.00
7/3/2015	12:15:00 PM	0.00
7/3/2015	12:30:00 PM	0.00
7/3/2015	12:45:00 PM	0.00
7/3/2015	1:00:00 PM	0.00
7/3/2015	1:15:00 PM	0.00
7/3/2015	1:30:00 PM	0.00
7/3/2015	1:45:00 PM	0.00
7/3/2015	2:00:00 PM	0.00
7/3/2015	2:15:00 PM	0.00
7/3/2015	2:30:00 PM	0.00
7/3/2015	2:45:00 PM	0.00
7/3/2015	3:00:00 PM	0.00
7/3/2015	3:15:00 PM	0.00
7/3/2015	3:30:00 PM	0.00
7/3/2015	3:45:00 PM	0.00
7/3/2015	4:00:00 PM	0.00
7/3/2015	4:15:00 PM	0.00
7/3/2015	4:30:00 PM	0.00
7/3/2015	4:45:00 PM	0.00
7/3/2015	5:00:00 PM	0.00
7/3/2015	5:15:00 PM	0.00
7/3/2015	5:30:00 PM	0.00
7/3/2015	5:45:00 PM	0.00
7/3/2015	6:00:00 PM	0.00
7/3/2015	6:15:00 PM	0.00
7/3/2015	6:30:00 PM	0.00
7/3/2015	6:45:00 PM	0.00
7/3/2015	7:00:00 PM	0.00
7/3/2015	7:15:00 PM	0.00
7/3/2015	7:30:00 PM	0.00
7/3/2015	7:45:00 PM	0.00
7/3/2015	8:00:00 PM	0.00
7/3/2015	8:15:00 PM	0.00
7/3/2015	8:30:00 PM	0.00
7/3/2015	8:45:00 PM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/3/2015	9:00:00 PM	0.00
7/3/2015	9:15:00 PM	0.00
7/3/2015	9:30:00 PM	0.00
7/3/2015	9:45:00 PM	0.00
7/3/2015	10:00:00 PM	0.00
7/3/2015	10:15:00 PM	0.00
7/3/2015	10:30:00 PM	0.00
7/3/2015	10:45:00 PM	0.00
7/3/2015	11:00:00 PM	0.00
7/3/2015	11:15:00 PM	0.00
7/3/2015	11:30:00 PM	0.00
7/3/2015	11:45:00 PM	0.00
7/4/2015	12:00:00 AM	0.00
7/4/2015	12:15:00 AM	0.00
7/4/2015	12:30:00 AM	0.00
7/4/2015	12:45:00 AM	0.00
7/4/2015	1:00:00 AM	0.00
7/4/2015	1:15:00 AM	0.00
7/4/2015	1:30:00 AM	0.00
7/4/2015	1:45:00 AM	0.00
7/4/2015	2:00:00 AM	0.00
7/4/2015	2:15:00 AM	0.00
7/4/2015	2:30:00 AM	0.00
7/4/2015	2:45:00 AM	0.00
7/4/2015	3:00:00 AM	0.00
7/4/2015	3:15:00 AM	0.00
7/4/2015	3:30:00 AM	0.00
7/4/2015	3:45:00 AM	0.00
7/4/2015	4:00:00 AM	0.00
7/4/2015	4:15:00 AM	0.00
7/4/2015	4:30:00 AM	0.00
7/4/2015	4:45:00 AM	0.00
7/4/2015	5:00:00 AM	0.00
7/4/2015	5:15:00 AM	0.00
7/4/2015	5:30:00 AM	0.00
7/4/2015	5:45:00 AM	0.00
7/4/2015	6:00:00 AM	0.00
7/4/2015	6:15:00 AM	0.00
7/4/2015	6:30:00 AM	0.00
7/4/2015	6:45:00 AM	0.00
7/4/2015	7:00:00 AM	0.00
7/4/2015	7:15:00 AM	0.00
7/4/2015	7:30:00 AM	0.00
7/4/2015	7:45:00 AM	0.00
7/4/2015	8:00:00 AM	0.00
7/4/2015	8:15:00 AM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/4/2015	8:30:00 AM	0.00
7/4/2015	8:45:00 AM	0.00
7/4/2015	9:00:00 AM	0.00
7/4/2015	9:15:00 AM	0.00
7/4/2015	9:30:00 AM	0.00
7/4/2015	9:45:00 AM	0.00
7/4/2015	10:00:00 AM	0.00
7/4/2015	10:15:00 AM	0.00
7/4/2015	10:30:00 AM	0.00
7/4/2015	10:45:00 AM	0.00
7/4/2015	11:00:00 AM	0.00
7/4/2015	11:15:00 AM	0.00
7/4/2015	11:30:00 AM	0.00
7/4/2015	11:45:00 AM	0.00
7/4/2015	12:00:00 PM	0.00
7/4/2015	12:15:00 PM	0.00
7/4/2015	12:30:00 PM	0.00
7/4/2015	12:45:00 PM	0.00
7/4/2015	1:00:00 PM	0.00
7/4/2015	1:15:00 PM	0.00
7/4/2015	1:30:00 PM	0.00
7/4/2015	1:45:00 PM	0.00
7/4/2015	2:00:00 PM	0.00
7/4/2015	2:15:00 PM	0.00
7/4/2015	2:30:00 PM	0.00
7/4/2015	2:45:00 PM	0.00
7/4/2015	3:00:00 PM	0.00
7/4/2015	3:15:00 PM	0.00
7/4/2015	3:30:00 PM	0.00
7/4/2015	3:45:00 PM	0.00
7/4/2015	4:00:00 PM	0.00
7/4/2015	4:15:00 PM	0.00
7/4/2015	4:30:00 PM	0.00
7/4/2015	4:45:00 PM	0.00
7/4/2015	5:00:00 PM	0.00
7/4/2015	5:15:00 PM	0.00
7/4/2015	5:30:00 PM	0.00
7/4/2015	5:45:00 PM	0.00
7/4/2015	6:00:00 PM	0.00
7/4/2015	6:15:00 PM	0.00
7/4/2015	6:30:00 PM	0.00
7/4/2015	6:45:00 PM	0.00
7/4/2015	7:00:00 PM	0.00
7/4/2015	7:15:00 PM	0.00
7/4/2015	7:30:00 PM	0.00
7/4/2015	7:45:00 PM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/4/2015	8:00:00 PM	0.00
7/4/2015	8:15:00 PM	0.00
7/4/2015	8:30:00 PM	0.00
7/4/2015	8:45:00 PM	0.00
7/4/2015	9:00:00 PM	0.00
7/4/2015	9:15:00 PM	0.00
7/4/2015	9:30:00 PM	0.00
7/4/2015	9:45:00 PM	0.00
7/4/2015	10:00:00 PM	0.00
7/4/2015	10:15:00 PM	0.00
7/4/2015	10:30:00 PM	0.00
7/4/2015	10:45:00 PM	0.00
7/4/2015	11:00:00 PM	0.00
7/4/2015	11:15:00 PM	0.00
7/4/2015	11:30:00 PM	0.00
7/4/2015	11:45:00 PM	0.00
7/5/2015	12:00:00 AM	0.00
7/5/2015	12:15:00 AM	0.00
7/5/2015	12:30:00 AM	0.00
7/5/2015	12:45:00 AM	0.00
7/5/2015	1:00:00 AM	0.00
7/5/2015	1:15:00 AM	0.00
7/5/2015	1:30:00 AM	0.00
7/5/2015	1:45:00 AM	0.00
7/5/2015	2:00:00 AM	0.00
7/5/2015	2:15:00 AM	0.00
7/5/2015	2:30:00 AM	0.00
7/5/2015	2:45:00 AM	0.00
7/5/2015	3:00:00 AM	0.00
7/5/2015	3:15:00 AM	0.00
7/5/2015	3:30:00 AM	0.00
7/5/2015	3:45:00 AM	0.00
7/5/2015	4:00:00 AM	0.00
7/5/2015	4:15:00 AM	0.00
7/5/2015	4:30:00 AM	0.00
7/5/2015	4:45:00 AM	0.00
7/5/2015	5:00:00 AM	0.00
7/5/2015	5:15:00 AM	0.00
7/5/2015	5:30:00 AM	0.00
7/5/2015	5:45:00 AM	0.00
7/5/2015	6:00:00 AM	0.00
7/5/2015	6:15:00 AM	0.00
7/5/2015	6:30:00 AM	0.00
7/5/2015	6:45:00 AM	0.00
7/5/2015	7:00:00 AM	0.00
7/5/2015	7:15:00 AM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/5/2015	7:30:00 AM	0.00
7/5/2015	7:45:00 AM	0.00
7/5/2015	8:00:00 AM	0.00
7/5/2015	8:15:00 AM	0.00
7/5/2015	8:30:00 AM	0.00
7/5/2015	8:45:00 AM	0.00
7/5/2015	9:00:00 AM	0.00
7/5/2015	9:15:00 AM	0.00
7/5/2015	9:30:00 AM	0.00
7/5/2015	9:45:00 AM	0.00
7/5/2015	10:00:00 AM	0.00
7/5/2015	10:15:00 AM	0.00
7/5/2015	10:30:00 AM	0.00
7/5/2015	10:45:00 AM	0.00
7/5/2015	11:00:00 AM	0.00
7/5/2015	11:15:00 AM	0.00
7/5/2015	11:30:00 AM	0.00
7/5/2015	11:45:00 AM	0.00
7/5/2015	12:00:00 PM	0.00
7/5/2015	12:15:00 PM	0.00
7/5/2015	12:30:00 PM	0.00
7/5/2015	12:45:00 PM	0.00
7/5/2015	1:00:00 PM	0.00
7/5/2015	1:15:00 PM	0.00
7/5/2015	1:30:00 PM	0.00
7/5/2015	1:45:00 PM	0.00
7/5/2015	2:00:00 PM	0.00
7/5/2015	2:15:00 PM	0.00
7/5/2015	2:30:00 PM	0.00
7/5/2015	2:45:00 PM	0.00
7/5/2015	3:00:00 PM	0.00
7/5/2015	3:15:00 PM	0.00
7/5/2015	3:30:00 PM	0.00
7/5/2015	3:45:00 PM	0.00
7/5/2015	4:00:00 PM	0.00
7/5/2015	4:15:00 PM	0.00
7/5/2015	4:30:00 PM	0.00
7/5/2015	4:45:00 PM	0.00
7/5/2015	5:00:00 PM	0.00
7/5/2015	5:15:00 PM	0.00
7/5/2015	5:30:00 PM	0.00
7/5/2015	5:45:00 PM	0.00
7/5/2015	6:00:00 PM	0.00
7/5/2015	6:15:00 PM	0.00
7/5/2015	6:30:00 PM	0.00
7/5/2015	6:45:00 PM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/5/2015	7:00:00 PM	0.00
7/5/2015	7:15:00 PM	0.00
7/5/2015	7:30:00 PM	0.00
7/5/2015	7:45:00 PM	0.00
7/5/2015	8:00:00 PM	0.00
7/5/2015	8:15:00 PM	0.00
7/5/2015	8:30:00 PM	0.00
7/5/2015	8:45:00 PM	0.00
7/5/2015	9:00:00 PM	0.00
7/5/2015	9:15:00 PM	0.00
7/5/2015	9:30:00 PM	0.00
7/5/2015	9:45:00 PM	0.00
7/5/2015	10:00:00 PM	0.00
7/5/2015	10:15:00 PM	0.00
7/5/2015	10:30:00 PM	0.00
7/5/2015	10:45:00 PM	0.00
7/5/2015	11:00:00 PM	0.00
7/5/2015	11:15:00 PM	0.00
7/5/2015	11:30:00 PM	0.00
7/5/2015	11:45:00 PM	0.00
7/6/2015	12:00:00 AM	0.00
7/6/2015	12:15:00 AM	0.00
7/6/2015	12:30:00 AM	0.00
7/6/2015	12:45:00 AM	0.00
7/6/2015	1:00:00 AM	0.00
7/6/2015	1:15:00 AM	0.00
7/6/2015	1:30:00 AM	0.00
7/6/2015	1:45:00 AM	0.00
7/6/2015	2:00:00 AM	0.00
7/6/2015	2:15:00 AM	0.00
7/6/2015	2:30:00 AM	0.00
7/6/2015	2:45:00 AM	0.00
7/6/2015	3:00:00 AM	0.00
7/6/2015	3:15:00 AM	0.00
7/6/2015	3:30:00 AM	0.00
7/6/2015	3:45:00 AM	0.00
7/6/2015	4:00:00 AM	0.00
7/6/2015	4:15:00 AM	0.00
7/6/2015	4:30:00 AM	0.00
7/6/2015	4:45:00 AM	0.00
7/6/2015	5:00:00 AM	0.00
7/6/2015	5:15:00 AM	0.00
7/6/2015	5:30:00 AM	0.00
7/6/2015	5:45:00 AM	0.00
7/6/2015	6:00:00 AM	0.00
7/6/2015	6:15:00 AM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/6/2015	6:30:00 AM	0.00
7/6/2015	6:45:00 AM	0.00
7/6/2015	7:00:00 AM	0.00
7/6/2015	7:15:00 AM	0.00
7/6/2015	7:30:00 AM	0.00
7/6/2015	7:45:00 AM	0.00
7/6/2015	8:00:00 AM	0.00
7/6/2015	8:15:00 AM	0.00
7/6/2015	8:30:00 AM	0.00
7/6/2015	8:45:00 AM	0.00
7/6/2015	9:00:00 AM	0.00
7/6/2015	9:15:00 AM	0.00
7/6/2015	9:30:00 AM	0.00
7/6/2015	9:45:00 AM	0.00
7/6/2015	10:00:00 AM	0.00
7/6/2015	10:15:00 AM	0.00
7/6/2015	10:30:00 AM	0.00
7/6/2015	10:45:00 AM	0.00
7/6/2015	11:00:00 AM	0.00
7/6/2015	11:15:00 AM	0.00
7/6/2015	11:30:00 AM	0.00
7/6/2015	11:45:00 AM	0.00
7/6/2015	12:00:00 PM	0.00
7/6/2015	12:15:00 PM	0.00
7/6/2015	12:30:00 PM	0.00
7/6/2015	12:45:00 PM	0.00
7/6/2015	1:00:00 PM	0.00
7/6/2015	1:15:00 PM	0.00
7/6/2015	1:30:00 PM	0.00
7/6/2015	1:45:00 PM	0.00
7/6/2015	2:00:00 PM	0.00
7/6/2015	2:15:00 PM	0.00
7/6/2015	2:30:00 PM	0.00
7/6/2015	2:45:00 PM	0.00
7/6/2015	3:00:00 PM	0.00
7/6/2015	3:15:00 PM	0.00
7/6/2015	3:30:00 PM	0.00
7/6/2015	3:45:00 PM	0.00
7/6/2015	4:00:00 PM	0.00
7/6/2015	4:15:00 PM	0.00
7/6/2015	4:30:00 PM	0.00
7/6/2015	4:45:00 PM	0.00
7/6/2015	5:00:00 PM	0.00
7/6/2015	5:15:00 PM	0.00
7/6/2015	5:30:00 PM	0.00
7/6/2015	5:45:00 PM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/6/2015	6:00:00 PM	0.00
7/6/2015	6:15:00 PM	0.00
7/6/2015	6:30:00 PM	0.00
7/6/2015	6:45:00 PM	0.00
7/6/2015	7:00:00 PM	0.00
7/6/2015	7:15:00 PM	0.00
7/6/2015	7:30:00 PM	0.00
7/6/2015	7:45:00 PM	0.00
7/6/2015	8:00:00 PM	0.00
7/6/2015	8:15:00 PM	0.00
7/6/2015	8:30:00 PM	0.00
7/6/2015	8:45:00 PM	0.00
7/6/2015	9:00:00 PM	0.00
7/6/2015	9:15:00 PM	0.00
7/6/2015	9:30:00 PM	0.00
7/6/2015	9:45:00 PM	0.00
7/6/2015	10:00:00 PM	0.00
7/6/2015	10:15:00 PM	0.00
7/6/2015	10:30:00 PM	0.00
7/6/2015	10:45:00 PM	0.00
7/6/2015	11:00:00 PM	0.00
7/6/2015	11:15:00 PM	0.00
7/6/2015	11:30:00 PM	0.00
7/6/2015	11:45:00 PM	0.00
7/7/2015	12:00:00 AM	0.00
7/7/2015	12:15:00 AM	0.00
7/7/2015	12:30:00 AM	0.00
7/7/2015	12:45:00 AM	0.00
7/7/2015	1:00:00 AM	0.00
7/7/2015	1:15:00 AM	0.00
7/7/2015	1:30:00 AM	0.00
7/7/2015	1:45:00 AM	0.00
7/7/2015	2:00:00 AM	0.00
7/7/2015	2:15:00 AM	0.00
7/7/2015	2:30:00 AM	0.00
7/7/2015	2:45:00 AM	0.00
7/7/2015	3:00:00 AM	0.00
7/7/2015	3:15:00 AM	0.00
7/7/2015	3:30:00 AM	0.00
7/7/2015	3:45:00 AM	0.00
7/7/2015	4:00:00 AM	0.00
7/7/2015	4:15:00 AM	0.00
7/7/2015	4:30:00 AM	0.00
7/7/2015	4:45:00 AM	0.00
7/7/2015	5:00:00 AM	0.00
7/7/2015	5:15:00 AM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/7/2015	5:30:00 AM	0.00
7/7/2015	5:45:00 AM	0.00
7/7/2015	6:00:00 AM	0.00
7/7/2015	6:15:00 AM	0.00
7/7/2015	6:30:00 AM	0.00
7/7/2015	6:45:00 AM	0.00
7/7/2015	7:00:00 AM	0.00
7/7/2015	7:15:00 AM	0.00
7/7/2015	7:30:00 AM	0.00
7/7/2015	7:45:00 AM	0.00
7/7/2015	8:00:00 AM	0.00
7/7/2015	8:15:00 AM	0.00
7/7/2015	8:30:00 AM	0.00
7/7/2015	8:45:00 AM	0.00
7/7/2015	9:00:00 AM	0.00
7/7/2015	9:15:00 AM	0.00
7/7/2015	9:30:00 AM	0.00
7/7/2015	9:45:00 AM	0.00
7/7/2015	10:00:00 AM	0.00
7/7/2015	10:15:00 AM	0.00
7/7/2015	10:30:00 AM	0.00
7/7/2015	10:45:00 AM	0.00
7/7/2015	11:00:00 AM	0.00
7/7/2015	11:15:00 AM	0.00
7/7/2015	11:30:00 AM	0.00
7/7/2015	11:45:00 AM	0.00
7/7/2015	12:00:00 PM	0.00
7/7/2015	12:15:00 PM	0.00
7/7/2015	12:30:00 PM	0.00
7/7/2015	12:45:00 PM	0.00
7/7/2015	1:00:00 PM	0.00
7/7/2015	1:15:00 PM	0.00
7/7/2015	1:30:00 PM	0.00
7/7/2015	1:45:00 PM	0.00
7/7/2015	2:00:00 PM	0.00
7/7/2015	2:15:00 PM	0.00
7/7/2015	2:30:00 PM	0.00
7/7/2015	2:45:00 PM	0.00
7/7/2015	3:00:00 PM	0.00
7/7/2015	3:15:00 PM	0.00
7/7/2015	3:30:00 PM	0.00
7/7/2015	3:45:00 PM	0.00
7/7/2015	4:00:00 PM	0.00
7/7/2015	4:15:00 PM	0.00
7/7/2015	4:30:00 PM	0.00
7/7/2015	4:45:00 PM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/7/2015	5:00:00 PM	0.00
7/7/2015	5:15:00 PM	0.00
7/7/2015	5:30:00 PM	0.00
7/7/2015	5:45:00 PM	0.00
7/7/2015	6:00:00 PM	0.00
7/7/2015	6:15:00 PM	0.00
7/7/2015	6:30:00 PM	0.00
7/7/2015	6:45:00 PM	0.00
7/7/2015	7:00:00 PM	0.00
7/7/2015	7:15:00 PM	0.00
7/7/2015	7:30:00 PM	0.00
7/7/2015	7:45:00 PM	0.00
7/7/2015	8:00:00 PM	0.00
7/7/2015	8:15:00 PM	0.00
7/7/2015	8:30:00 PM	0.00
7/7/2015	8:45:00 PM	0.00
7/7/2015	9:00:00 PM	0.00
7/7/2015	9:15:00 PM	0.00
7/7/2015	9:30:00 PM	0.00
7/7/2015	9:45:00 PM	0.00
7/7/2015	10:00:00 PM	0.00
7/7/2015	10:15:00 PM	0.00
7/7/2015	10:30:00 PM	0.00
7/7/2015	10:45:00 PM	0.00
7/7/2015	11:00:00 PM	0.00
7/7/2015	11:15:00 PM	0.00
7/7/2015	11:30:00 PM	0.00
7/7/2015	11:45:00 PM	0.00
7/8/2015	12:00:00 AM	0.00
7/8/2015	12:15:00 AM	0.00
7/8/2015	12:30:00 AM	0.00
7/8/2015	12:45:00 AM	0.00
7/8/2015	1:00:00 AM	0.00
7/8/2015	1:15:00 AM	0.00
7/8/2015	1:30:00 AM	0.00
7/8/2015	1:45:00 AM	0.00
7/8/2015	2:00:00 AM	0.00
7/8/2015	2:15:00 AM	0.00
7/8/2015	2:30:00 AM	0.00
7/8/2015	2:45:00 AM	0.00
7/8/2015	3:00:00 AM	0.00
7/8/2015	3:15:00 AM	0.00
7/8/2015	3:30:00 AM	0.00
7/8/2015	3:45:00 AM	0.00
7/8/2015	4:00:00 AM	0.00
7/8/2015	4:15:00 AM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/8/2015	4:30:00 AM	0.00
7/8/2015	4:45:00 AM	0.00
7/8/2015	5:00:00 AM	0.00
7/8/2015	5:15:00 AM	0.00
7/8/2015	5:30:00 AM	0.00
7/8/2015	5:45:00 AM	0.00
7/8/2015	6:00:00 AM	0.00
7/8/2015	6:15:00 AM	0.00
7/8/2015	6:30:00 AM	0.00
7/8/2015	6:45:00 AM	0.00
7/8/2015	7:00:00 AM	0.00
7/8/2015	7:15:00 AM	0.00
7/8/2015	7:30:00 AM	0.00
7/8/2015	7:45:00 AM	0.00
7/8/2015	8:00:00 AM	0.00
7/8/2015	8:15:00 AM	0.00
7/8/2015	8:30:00 AM	0.00
7/8/2015	8:45:00 AM	0.00
7/8/2015	9:00:00 AM	0.00
7/8/2015	9:15:00 AM	0.00
7/8/2015	9:30:00 AM	0.00
7/8/2015	9:45:00 AM	0.00
7/8/2015	10:00:00 AM	0.00
7/8/2015	10:15:00 AM	0.00
7/8/2015	10:30:00 AM	0.00
7/8/2015	10:45:00 AM	0.00
7/8/2015	11:00:00 AM	0.00
7/8/2015	11:15:00 AM	0.00
7/8/2015	11:30:00 AM	0.00
7/8/2015	11:45:00 AM	0.00
7/8/2015	12:00:00 PM	0.00
7/8/2015	12:15:00 PM	0.00
7/8/2015	12:30:00 PM	0.00
7/8/2015	12:45:00 PM	0.00
7/8/2015	1:00:00 PM	0.00
7/8/2015	1:15:00 PM	0.00
7/8/2015	1:30:00 PM	0.00
7/8/2015	1:45:00 PM	0.00
7/8/2015	2:00:00 PM	0.00
7/8/2015	2:15:00 PM	0.00
7/8/2015	2:30:00 PM	0.00
7/8/2015	2:45:00 PM	0.00
7/8/2015	3:00:00 PM	0.00
7/8/2015	3:15:00 PM	0.00
7/8/2015	3:30:00 PM	0.00
7/8/2015	3:45:00 PM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/8/2015	4:00:00 PM	0.00
7/8/2015	4:15:00 PM	0.00
7/8/2015	4:30:00 PM	0.00
7/8/2015	4:45:00 PM	0.00
7/8/2015	5:00:00 PM	0.00
7/8/2015	5:15:00 PM	0.00
7/8/2015	5:30:00 PM	0.00
7/8/2015	5:45:00 PM	0.00
7/8/2015	6:00:00 PM	0.00
7/8/2015	6:15:00 PM	0.00
7/8/2015	6:30:00 PM	0.00
7/8/2015	6:45:00 PM	0.00
7/8/2015	7:00:00 PM	0.00
7/8/2015	7:15:00 PM	0.00
7/8/2015	7:30:00 PM	0.00
7/8/2015	7:45:00 PM	0.00
7/8/2015	8:00:00 PM	0.00
7/8/2015	8:15:00 PM	0.00
7/8/2015	8:30:00 PM	0.00
7/8/2015	8:45:00 PM	0.00
7/8/2015	9:00:00 PM	0.00
7/8/2015	9:15:00 PM	0.00
7/8/2015	9:30:00 PM	0.00
7/8/2015	9:45:00 PM	0.00
7/8/2015	10:00:00 PM	0.00
7/8/2015	10:15:00 PM	0.00
7/8/2015	10:30:00 PM	0.00
7/8/2015	10:45:00 PM	0.00
7/8/2015	11:00:00 PM	0.00
7/8/2015	11:15:00 PM	0.00
7/8/2015	11:30:00 PM	0.00
7/8/2015	11:45:00 PM	0.00
7/9/2015	12:00:00 AM	0.00
7/9/2015	12:15:00 AM	0.00
7/9/2015	12:30:00 AM	0.00
7/9/2015	12:45:00 AM	0.00
7/9/2015	1:00:00 AM	0.00
7/9/2015	1:15:00 AM	0.00
7/9/2015	1:30:00 AM	0.00
7/9/2015	1:45:00 AM	0.00
7/9/2015	2:00:00 AM	0.00
7/9/2015	2:15:00 AM	0.00
7/9/2015	2:30:00 AM	0.00
7/9/2015	2:45:00 AM	0.00
7/9/2015	3:00:00 AM	0.00
7/9/2015	3:15:00 AM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/9/2015	3:30:00 AM	0.00
7/9/2015	3:45:00 AM	0.00
7/9/2015	4:00:00 AM	0.00
7/9/2015	4:15:00 AM	0.00
7/9/2015	4:30:00 AM	0.00
7/9/2015	4:45:00 AM	0.00
7/9/2015	5:00:00 AM	0.00
7/9/2015	5:15:00 AM	0.00
7/9/2015	5:30:00 AM	0.00
7/9/2015	5:45:00 AM	0.00
7/9/2015	6:00:00 AM	0.00
7/9/2015	6:15:00 AM	0.00
7/9/2015	6:30:00 AM	0.00
7/9/2015	6:45:00 AM	0.00
7/9/2015	7:00:00 AM	0.00
7/9/2015	7:15:00 AM	0.00
7/9/2015	7:30:00 AM	0.00
7/9/2015	7:45:00 AM	0.00
7/9/2015	8:00:00 AM	0.00
7/9/2015	8:15:00 AM	0.00
7/9/2015	8:30:00 AM	0.00
7/9/2015	8:45:00 AM	0.00
7/9/2015	9:00:00 AM	0.00
7/9/2015	9:15:00 AM	0.00
7/9/2015	9:30:00 AM	0.00
7/9/2015	9:45:00 AM	0.00
7/9/2015	10:00:00 AM	0.00
7/9/2015	10:15:00 AM	0.00
7/9/2015	10:30:00 AM	0.00
7/9/2015	10:45:00 AM	0.00
7/9/2015	11:00:00 AM	0.00
7/9/2015	11:15:00 AM	0.00
7/9/2015	11:30:00 AM	0.00
7/9/2015	11:45:00 AM	0.00
7/9/2015	12:00:00 PM	0.00
7/9/2015	12:15:00 PM	0.00
7/9/2015	12:30:00 PM	0.00
7/9/2015	12:45:00 PM	0.00
7/9/2015	1:00:00 PM	0.00
7/9/2015	1:15:00 PM	0.00
7/9/2015	1:30:00 PM	0.00
7/9/2015	1:45:00 PM	0.00
7/9/2015	2:00:00 PM	0.00
7/9/2015	2:15:00 PM	0.00
7/9/2015	2:30:00 PM	0.00
7/9/2015	2:45:00 PM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/9/2015	3:00:00 PM	0.00
7/9/2015	3:15:00 PM	0.00
7/9/2015	3:30:00 PM	0.00
7/9/2015	3:45:00 PM	0.00
7/9/2015	4:00:00 PM	0.00
7/9/2015	4:15:00 PM	0.00
7/9/2015	4:30:00 PM	0.00
7/9/2015	4:45:00 PM	0.00
7/9/2015	5:00:00 PM	0.00
7/9/2015	5:15:00 PM	0.00
7/9/2015	5:30:00 PM	0.00
7/9/2015	5:45:00 PM	0.00
7/9/2015	6:00:00 PM	0.00
7/9/2015	6:15:00 PM	0.00
7/9/2015	6:30:00 PM	0.00
7/9/2015	6:45:00 PM	0.00
7/9/2015	7:00:00 PM	0.00
7/9/2015	7:15:00 PM	0.00
7/9/2015	7:30:00 PM	0.00
7/9/2015	7:45:00 PM	0.00
7/9/2015	8:00:00 PM	0.00
7/9/2015	8:15:00 PM	0.00
7/9/2015	8:30:00 PM	0.00
7/9/2015	8:45:00 PM	0.00
7/9/2015	9:00:00 PM	0.00
7/9/2015	9:15:00 PM	0.00
7/9/2015	9:30:00 PM	0.00
7/9/2015	9:45:00 PM	0.00
7/9/2015	10:00:00 PM	0.00
7/9/2015	10:15:00 PM	0.00
7/9/2015	10:30:00 PM	0.00
7/9/2015	10:45:00 PM	0.00
7/9/2015	11:00:00 PM	0.00
7/9/2015	11:15:00 PM	0.00
7/9/2015	11:30:00 PM	0.00
7/9/2015	11:45:00 PM	0.00
7/10/2015	12:00:00 AM	0.00
7/10/2015	12:15:00 AM	0.00
7/10/2015	12:30:00 AM	0.00
7/10/2015	12:45:00 AM	0.00
7/10/2015	1:00:00 AM	0.00
7/10/2015	1:15:00 AM	0.00
7/10/2015	1:30:00 AM	0.00
7/10/2015	1:45:00 AM	0.00
7/10/2015	2:00:00 AM	0.00
7/10/2015	2:15:00 AM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/10/2015	2:30:00 AM	0.00
7/10/2015	2:45:00 AM	0.00
7/10/2015	3:00:00 AM	0.00
7/10/2015	3:15:00 AM	0.00
7/10/2015	3:30:00 AM	0.00
7/10/2015	3:45:00 AM	0.00
7/10/2015	4:00:00 AM	0.00
7/10/2015	4:15:00 AM	0.00
7/10/2015	4:30:00 AM	0.00
7/10/2015	4:45:00 AM	0.00
7/10/2015	5:00:00 AM	0.00
7/10/2015	5:15:00 AM	0.00
7/10/2015	5:30:00 AM	0.00
7/10/2015	5:45:00 AM	0.00
7/10/2015	6:00:00 AM	0.00
7/10/2015	6:15:00 AM	0.00
7/10/2015	6:30:00 AM	0.00
7/10/2015	6:45:00 AM	0.00
7/10/2015	7:00:00 AM	0.00
7/10/2015	7:15:00 AM	0.00
7/10/2015	7:30:00 AM	0.00
7/10/2015	7:45:00 AM	0.00
7/10/2015	8:00:00 AM	0.00
7/10/2015	8:15:00 AM	0.00
7/10/2015	8:30:00 AM	0.00
7/10/2015	8:45:00 AM	0.00
7/10/2015	9:00:00 AM	0.00
7/10/2015	9:15:00 AM	0.00
7/10/2015	9:30:00 AM	0.00
7/10/2015	9:45:00 AM	0.00
7/10/2015	10:00:00 AM	0.00
7/10/2015	10:15:00 AM	0.00
7/10/2015	10:30:00 AM	0.00
7/10/2015	10:45:00 AM	0.00
7/10/2015	11:00:00 AM	0.00
7/10/2015	11:15:00 AM	0.00
7/10/2015	11:30:00 AM	0.00
7/10/2015	11:45:00 AM	0.00
7/10/2015	12:00:00 PM	0.00
7/10/2015	12:15:00 PM	0.00
7/10/2015	12:30:00 PM	0.00
7/10/2015	12:45:00 PM	0.00
7/10/2015	1:00:00 PM	0.00
7/10/2015	1:15:00 PM	0.00
7/10/2015	1:30:00 PM	0.00
7/10/2015	1:45:00 PM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/10/2015	2:00:00 PM	0.00
7/10/2015	2:15:00 PM	0.00
7/10/2015	2:30:00 PM	0.00
7/10/2015	2:45:00 PM	0.00
7/10/2015	3:00:00 PM	0.00
7/10/2015	3:15:00 PM	0.00
7/10/2015	3:30:00 PM	0.00
7/10/2015	3:45:00 PM	0.00
7/10/2015	4:00:00 PM	0.00
7/10/2015	4:15:00 PM	0.00
7/10/2015	4:30:00 PM	0.00
7/10/2015	4:45:00 PM	0.00
7/10/2015	5:00:00 PM	0.00
7/10/2015	5:15:00 PM	0.00
7/10/2015	5:30:00 PM	0.00
7/10/2015	5:45:00 PM	0.00
7/10/2015	6:00:00 PM	0.00
7/10/2015	6:15:00 PM	0.00
7/10/2015	6:30:00 PM	0.00
7/10/2015	6:45:00 PM	0.00
7/10/2015	7:00:00 PM	0.00
7/10/2015	7:15:00 PM	0.00
7/10/2015	7:30:00 PM	0.00
7/10/2015	7:45:00 PM	0.00
7/10/2015	8:00:00 PM	0.00
7/10/2015	8:15:00 PM	0.00
7/10/2015	8:30:00 PM	0.00
7/10/2015	8:45:00 PM	0.00
7/10/2015	9:00:00 PM	0.00
7/10/2015	9:15:00 PM	0.00
7/10/2015	9:30:00 PM	0.00
7/10/2015	9:45:00 PM	0.00
7/10/2015	10:00:00 PM	0.00
7/10/2015	10:15:00 PM	0.00
7/10/2015	10:30:00 PM	0.00
7/10/2015	10:45:00 PM	0.00
7/10/2015	11:00:00 PM	0.00
7/10/2015	11:15:00 PM	0.00
7/10/2015	11:30:00 PM	0.00
7/10/2015	11:45:00 PM	0.00
7/11/2015	12:00:00 AM	0.00
7/11/2015	12:15:00 AM	0.00
7/11/2015	12:30:00 AM	0.00
7/11/2015	12:45:00 AM	0.00
7/11/2015	1:00:00 AM	0.00
7/11/2015	1:15:00 AM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/11/2015	1:30:00 AM	0.00
7/11/2015	1:45:00 AM	0.00
7/11/2015	2:00:00 AM	0.00
7/11/2015	2:15:00 AM	0.00
7/11/2015	2:30:00 AM	0.00
7/11/2015	2:45:00 AM	0.00
7/11/2015	3:00:00 AM	0.00
7/11/2015	3:15:00 AM	0.00
7/11/2015	3:30:00 AM	0.00
7/11/2015	3:45:00 AM	0.00
7/11/2015	4:00:00 AM	0.00
7/11/2015	4:15:00 AM	0.00
7/11/2015	4:30:00 AM	0.00
7/11/2015	4:45:00 AM	0.00
7/11/2015	5:00:00 AM	0.00
7/11/2015	5:15:00 AM	0.00
7/11/2015	5:30:00 AM	0.00
7/11/2015	5:45:00 AM	0.00
7/11/2015	6:00:00 AM	0.00
7/11/2015	6:15:00 AM	0.00
7/11/2015	6:30:00 AM	0.00
7/11/2015	6:45:00 AM	0.00
7/11/2015	7:00:00 AM	0.00
7/11/2015	7:15:00 AM	0.00
7/11/2015	7:30:00 AM	0.00
7/11/2015	7:45:00 AM	0.00
7/11/2015	8:00:00 AM	0.00
7/11/2015	8:15:00 AM	0.00
7/11/2015	8:30:00 AM	0.00
7/11/2015	8:45:00 AM	0.00
7/11/2015	9:00:00 AM	0.00
7/11/2015	9:15:00 AM	0.00
7/11/2015	9:30:00 AM	0.00
7/11/2015	9:45:00 AM	0.00
7/11/2015	10:00:00 AM	0.00
7/11/2015	10:15:00 AM	0.00
7/11/2015	10:30:00 AM	0.00
7/11/2015	10:45:00 AM	0.00
7/11/2015	11:00:00 AM	0.00
7/11/2015	11:15:00 AM	0.00
7/11/2015	11:30:00 AM	0.00
7/11/2015	11:45:00 AM	0.00
7/11/2015	12:00:00 PM	0.00
7/11/2015	12:15:00 PM	0.00
7/11/2015	12:30:00 PM	0.00
7/11/2015	12:45:00 PM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/11/2015	1:00:00 PM	0.00
7/11/2015	1:15:00 PM	0.00
7/11/2015	1:30:00 PM	0.00
7/11/2015	1:45:00 PM	0.00
7/11/2015	2:00:00 PM	0.00
7/11/2015	2:15:00 PM	0.00
7/11/2015	2:30:00 PM	0.00
7/11/2015	2:45:00 PM	0.00
7/11/2015	3:00:00 PM	0.00
7/11/2015	3:15:00 PM	0.00
7/11/2015	3:30:00 PM	0.00
7/11/2015	3:45:00 PM	0.00
7/11/2015	4:00:00 PM	0.00
7/11/2015	4:15:00 PM	0.00
7/11/2015	4:30:00 PM	0.00
7/11/2015	4:45:00 PM	0.00
7/11/2015	5:00:00 PM	0.00
7/11/2015	5:15:00 PM	0.00
7/11/2015	5:30:00 PM	0.00
7/11/2015	5:45:00 PM	0.00
7/11/2015	6:00:00 PM	0.00
7/11/2015	6:15:00 PM	0.00
7/11/2015	6:30:00 PM	0.00
7/11/2015	6:45:00 PM	0.00
7/11/2015	7:00:00 PM	0.00
7/11/2015	7:15:00 PM	0.00
7/11/2015	7:30:00 PM	0.00
7/11/2015	7:45:00 PM	0.00
7/11/2015	8:00:00 PM	0.00
7/11/2015	8:15:00 PM	0.00
7/11/2015	8:30:00 PM	0.00
7/11/2015	8:45:00 PM	0.00
7/11/2015	9:00:00 PM	0.00
7/11/2015	9:15:00 PM	0.00
7/11/2015	9:30:00 PM	0.00
7/11/2015	9:45:00 PM	0.00
7/11/2015	10:00:00 PM	0.00
7/11/2015	10:15:00 PM	0.00
7/11/2015	10:30:00 PM	0.00
7/11/2015	10:45:00 PM	0.00
7/11/2015	11:00:00 PM	0.00
7/11/2015	11:15:00 PM	0.00
7/11/2015	11:30:00 PM	0.00
7/11/2015	11:45:00 PM	0.00
7/12/2015	12:00:00 AM	0.00
7/12/2015	12:15:00 AM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/12/2015	12:30:00 AM	0.00
7/12/2015	12:45:00 AM	0.00
7/12/2015	1:00:00 AM	0.00
7/12/2015	1:15:00 AM	0.00
7/12/2015	1:30:00 AM	0.00
7/12/2015	1:45:00 AM	0.00
7/12/2015	2:00:00 AM	0.00
7/12/2015	2:15:00 AM	0.00
7/12/2015	2:30:00 AM	0.00
7/12/2015	2:45:00 AM	0.00
7/12/2015	3:00:00 AM	0.00
7/12/2015	3:15:00 AM	0.00
7/12/2015	3:30:00 AM	0.00
7/12/2015	3:45:00 AM	0.00
7/12/2015	4:00:00 AM	0.00
7/12/2015	4:15:00 AM	0.00
7/12/2015	4:30:00 AM	0.00
7/12/2015	4:45:00 AM	0.00
7/12/2015	5:00:00 AM	0.00
7/12/2015	5:15:00 AM	0.00
7/12/2015	5:30:00 AM	0.00
7/12/2015	5:45:00 AM	0.00
7/12/2015	6:00:00 AM	0.00
7/12/2015	6:15:00 AM	0.00
7/12/2015	6:30:00 AM	0.00
7/12/2015	6:45:00 AM	0.00
7/12/2015	7:00:00 AM	0.00
7/12/2015	7:15:00 AM	0.00
7/12/2015	7:30:00 AM	0.00
7/12/2015	7:45:00 AM	0.00
7/12/2015	8:00:00 AM	0.00
7/12/2015	8:15:00 AM	0.00
7/12/2015	8:30:00 AM	0.00
7/12/2015	8:45:00 AM	0.00
7/12/2015	9:00:00 AM	0.00
7/12/2015	9:15:00 AM	0.00
7/12/2015	9:30:00 AM	0.00
7/12/2015	9:45:00 AM	0.00
7/12/2015	10:00:00 AM	0.00
7/12/2015	10:15:00 AM	0.00
7/12/2015	10:30:00 AM	0.00
7/12/2015	10:45:00 AM	0.00
7/12/2015	11:00:00 AM	0.00
7/12/2015	11:15:00 AM	0.00
7/12/2015	11:30:00 AM	0.00
7/12/2015	11:45:00 AM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/12/2015	12:00:00 PM	0.00
7/12/2015	12:15:00 PM	0.00
7/12/2015	12:30:00 PM	0.00
7/12/2015	12:45:00 PM	0.00
7/12/2015	1:00:00 PM	0.00
7/12/2015	1:15:00 PM	0.00
7/12/2015	1:30:00 PM	0.00
7/12/2015	1:45:00 PM	0.00
7/12/2015	2:00:00 PM	0.00
7/12/2015	2:15:00 PM	0.00
7/12/2015	2:30:00 PM	0.00
7/12/2015	2:45:00 PM	0.00
7/12/2015	3:00:00 PM	0.00
7/12/2015	3:15:00 PM	0.00
7/12/2015	3:30:00 PM	0.00
7/12/2015	3:45:00 PM	0.00
7/12/2015	4:00:00 PM	0.00
7/12/2015	4:15:00 PM	0.00
7/12/2015	4:30:00 PM	0.00
7/12/2015	4:45:00 PM	0.00
7/12/2015	5:00:00 PM	0.00
7/12/2015	5:15:00 PM	0.00
7/12/2015	5:30:00 PM	0.00
7/12/2015	5:45:00 PM	0.00
7/12/2015	6:00:00 PM	0.00
7/12/2015	6:15:00 PM	0.00
7/12/2015	6:30:00 PM	0.00
7/12/2015	6:45:00 PM	0.00
7/12/2015	7:00:00 PM	0.00
7/12/2015	7:15:00 PM	0.00
7/12/2015	7:30:00 PM	0.00
7/12/2015	7:45:00 PM	0.00
7/12/2015	8:00:00 PM	0.00
7/12/2015	8:15:00 PM	0.00
7/12/2015	8:30:00 PM	0.00
7/12/2015	8:45:00 PM	0.00
7/12/2015	9:00:00 PM	0.00
7/12/2015	9:15:00 PM	0.00
7/12/2015	9:30:00 PM	0.00
7/12/2015	9:45:00 PM	0.00
7/12/2015	10:00:00 PM	0.00
7/12/2015	10:15:00 PM	0.00
7/12/2015	10:30:00 PM	0.00
7/12/2015	10:45:00 PM	0.00
7/12/2015	11:00:00 PM	0.00
7/12/2015	11:15:00 PM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/12/2015	11:30:00 PM	0.00
7/12/2015	11:45:00 PM	0.00
7/13/2015	12:00:00 AM	0.00
7/13/2015	12:15:00 AM	0.00
7/13/2015	12:30:00 AM	0.00
7/13/2015	12:45:00 AM	0.00
7/13/2015	1:00:00 AM	0.00
7/13/2015	1:15:00 AM	0.00
7/13/2015	1:30:00 AM	0.00
7/13/2015	1:45:00 AM	0.00
7/13/2015	2:00:00 AM	0.00
7/13/2015	2:15:00 AM	0.00
7/13/2015	2:30:00 AM	0.00
7/13/2015	2:45:00 AM	0.00
7/13/2015	3:00:00 AM	0.00
7/13/2015	3:15:00 AM	0.00
7/13/2015	3:30:00 AM	0.00
7/13/2015	3:45:00 AM	0.00
7/13/2015	4:00:00 AM	0.00
7/13/2015	4:15:00 AM	0.00
7/13/2015	4:30:00 AM	0.00
7/13/2015	4:45:00 AM	0.00
7/13/2015	5:00:00 AM	0.00
7/13/2015	5:15:00 AM	0.00
7/13/2015	5:30:00 AM	0.00
7/13/2015	5:45:00 AM	0.00
7/13/2015	6:00:00 AM	0.00
7/13/2015	6:15:00 AM	0.00
7/13/2015	6:30:00 AM	0.00
7/13/2015	6:45:00 AM	0.00
7/13/2015	7:00:00 AM	0.00
7/13/2015	7:15:00 AM	0.00
7/13/2015	7:30:00 AM	0.00
7/13/2015	7:45:00 AM	0.00
7/13/2015	8:00:00 AM	0.00
7/13/2015	8:15:00 AM	0.00
7/13/2015	8:30:00 AM	0.00
7/13/2015	8:45:00 AM	0.00
7/13/2015	9:00:00 AM	0.00
7/13/2015	9:15:00 AM	0.00
7/13/2015	9:30:00 AM	0.00
7/13/2015	9:45:00 AM	0.00
7/13/2015	10:00:00 AM	0.00
7/13/2015	10:15:00 AM	0.00
7/13/2015	10:30:00 AM	0.00
7/13/2015	10:45:00 AM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/13/2015	11:00:00 AM	0.00
7/13/2015	11:15:00 AM	0.00
7/13/2015	11:30:00 AM	0.00
7/13/2015	11:45:00 AM	0.00
7/13/2015	12:00:00 PM	0.00
7/13/2015	12:15:00 PM	0.00
7/13/2015	12:30:00 PM	0.00
7/13/2015	12:45:00 PM	0.00
7/13/2015	1:00:00 PM	0.00
7/13/2015	1:15:00 PM	0.00
7/13/2015	1:30:00 PM	0.00
7/13/2015	1:45:00 PM	0.00
7/13/2015	2:00:00 PM	0.00
7/13/2015	2:15:00 PM	0.00
7/13/2015	2:30:00 PM	0.00
7/13/2015	2:45:00 PM	0.00
7/13/2015	3:00:00 PM	0.00
7/13/2015	3:15:00 PM	0.00
7/13/2015	3:30:00 PM	0.00
7/13/2015	3:45:00 PM	0.00
7/13/2015	4:00:00 PM	0.00
7/13/2015	4:15:00 PM	0.00
7/13/2015	4:30:00 PM	0.00
7/13/2015	4:45:00 PM	0.00
7/13/2015	5:00:00 PM	0.00
7/13/2015	5:15:00 PM	0.00
7/13/2015	5:30:00 PM	0.00
7/13/2015	5:45:00 PM	0.00
7/13/2015	6:00:00 PM	0.00
7/13/2015	6:15:00 PM	0.00
7/13/2015	6:30:00 PM	0.00
7/13/2015	6:45:00 PM	0.00
7/13/2015	7:00:00 PM	0.00
7/13/2015	7:15:00 PM	0.00
7/13/2015	7:30:00 PM	0.00
7/13/2015	7:45:00 PM	0.00
7/13/2015	8:00:00 PM	0.00
7/13/2015	8:15:00 PM	0.00
7/13/2015	8:30:00 PM	0.00
7/13/2015	8:45:00 PM	0.00
7/13/2015	9:00:00 PM	0.00
7/13/2015	9:15:00 PM	0.00
7/13/2015	9:30:00 PM	0.00
7/13/2015	9:45:00 PM	0.00
7/13/2015	10:00:00 PM	0.00
7/13/2015	10:15:00 PM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/13/2015	10:30:00 PM	0.00
7/13/2015	10:45:00 PM	0.00
7/13/2015	11:00:00 PM	0.00
7/13/2015	11:15:00 PM	0.00
7/13/2015	11:30:00 PM	0.00
7/13/2015	11:45:00 PM	0.00
7/14/2015	12:00:00 AM	0.00
7/14/2015	12:15:00 AM	0.00
7/14/2015	12:30:00 AM	0.00
7/14/2015	12:45:00 AM	0.00
7/14/2015	1:00:00 AM	0.00
7/14/2015	1:15:00 AM	0.00
7/14/2015	1:30:00 AM	0.00
7/14/2015	1:45:00 AM	0.00
7/14/2015	2:00:00 AM	0.00
7/14/2015	2:15:00 AM	0.00
7/14/2015	2:30:00 AM	0.00
7/14/2015	2:45:00 AM	0.00
7/14/2015	3:00:00 AM	0.00
7/14/2015	3:15:00 AM	0.00
7/14/2015	3:30:00 AM	0.00
7/14/2015	3:45:00 AM	0.00
7/14/2015	4:00:00 AM	0.00
7/14/2015	4:15:00 AM	0.00
7/14/2015	4:30:00 AM	0.00
7/14/2015	4:45:00 AM	0.00
7/14/2015	5:00:00 AM	0.00
7/14/2015	5:15:00 AM	0.00
7/14/2015	5:30:00 AM	0.00
7/14/2015	5:45:00 AM	0.00
7/14/2015	6:00:00 AM	0.00
7/14/2015	6:15:00 AM	0.00
7/14/2015	6:30:00 AM	0.00
7/14/2015	6:45:00 AM	0.00
7/14/2015	7:00:00 AM	0.00
7/14/2015	7:15:00 AM	0.00
7/14/2015	7:30:00 AM	0.00
7/14/2015	7:45:00 AM	0.00
7/14/2015	8:00:00 AM	0.00
7/14/2015	8:15:00 AM	0.00
7/14/2015	8:30:00 AM	0.00
7/14/2015	8:45:00 AM	0.00
7/14/2015	9:00:00 AM	0.00
7/14/2015	9:15:00 AM	0.00
7/14/2015	9:30:00 AM	0.00
7/14/2015	9:45:00 AM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/14/2015	10:00:00 AM	0.00
7/14/2015	10:15:00 AM	0.00
7/14/2015	10:30:00 AM	0.00
7/14/2015	10:45:00 AM	0.00
7/14/2015	11:00:00 AM	0.00
7/14/2015	11:15:00 AM	0.00
7/14/2015	11:30:00 AM	0.00
7/14/2015	11:45:00 AM	0.00
7/14/2015	12:00:00 PM	0.00
7/14/2015	12:15:00 PM	0.00
7/14/2015	12:30:00 PM	0.00
7/14/2015	12:45:00 PM	0.00
7/14/2015	1:00:00 PM	0.00
7/14/2015	1:15:00 PM	0.00
7/14/2015	1:30:00 PM	0.00
7/14/2015	1:45:00 PM	0.00
7/14/2015	2:00:00 PM	0.00
7/14/2015	2:15:00 PM	0.00
7/14/2015	2:30:00 PM	0.00
7/14/2015	2:45:00 PM	0.00
7/14/2015	3:00:00 PM	0.00
7/14/2015	3:15:00 PM	0.00
7/14/2015	3:30:00 PM	0.00
7/14/2015	3:45:00 PM	0.00
7/14/2015	4:00:00 PM	0.00
7/14/2015	4:15:00 PM	0.00
7/14/2015	4:30:00 PM	0.00
7/14/2015	4:45:00 PM	0.00
7/14/2015	5:00:00 PM	0.00
7/14/2015	5:15:00 PM	0.00
7/14/2015	5:30:00 PM	0.00
7/14/2015	5:45:00 PM	0.00
7/14/2015	6:00:00 PM	0.00
7/14/2015	6:15:00 PM	0.00
7/14/2015	6:30:00 PM	0.00
7/14/2015	6:45:00 PM	0.00
7/14/2015	7:00:00 PM	0.00
7/14/2015	7:15:00 PM	0.00
7/14/2015	7:30:00 PM	0.00
7/14/2015	7:45:00 PM	0.00
7/14/2015	8:00:00 PM	0.00
7/14/2015	8:15:00 PM	0.00
7/14/2015	8:30:00 PM	0.00
7/14/2015	8:45:00 PM	0.00
7/14/2015	9:00:00 PM	0.00
7/14/2015	9:15:00 PM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/14/2015	9:30:00 PM	0.00
7/14/2015	9:45:00 PM	0.00
7/14/2015	10:00:00 PM	0.00
7/14/2015	10:15:00 PM	0.00
7/14/2015	10:30:00 PM	0.00
7/14/2015	10:45:00 PM	0.00
7/14/2015	11:00:00 PM	0.00
7/14/2015	11:15:00 PM	0.00
7/14/2015	11:30:00 PM	0.00
7/14/2015	11:45:00 PM	0.00
7/15/2015	12:00:00 AM	0.00
7/15/2015	12:15:00 AM	0.00
7/15/2015	12:30:00 AM	0.00
7/15/2015	12:45:00 AM	0.00
7/15/2015	1:00:00 AM	0.00
7/15/2015	1:15:00 AM	0.00
7/15/2015	1:30:00 AM	0.00
7/15/2015	1:45:00 AM	0.00
7/15/2015	2:00:00 AM	0.00
7/15/2015	2:15:00 AM	0.00
7/15/2015	2:30:00 AM	0.00
7/15/2015	2:45:00 AM	0.00
7/15/2015	3:00:00 AM	0.00
7/15/2015	3:15:00 AM	0.00
7/15/2015	3:30:00 AM	0.00
7/15/2015	3:45:00 AM	0.00
7/15/2015	4:00:00 AM	0.00
7/15/2015	4:15:00 AM	0.00
7/15/2015	4:30:00 AM	0.00
7/15/2015	4:45:00 AM	0.00
7/15/2015	5:00:00 AM	0.00
7/15/2015	5:15:00 AM	0.00
7/15/2015	5:30:00 AM	0.00
7/15/2015	5:45:00 AM	0.00
7/15/2015	6:00:00 AM	0.00
7/15/2015	6:15:00 AM	0.00
7/15/2015	6:30:00 AM	0.00
7/15/2015	6:45:00 AM	0.00
7/15/2015	7:00:00 AM	0.00
7/15/2015	7:15:00 AM	0.00
7/15/2015	7:30:00 AM	0.00
7/15/2015	7:45:00 AM	0.00
7/15/2015	8:00:00 AM	0.00
7/15/2015	8:15:00 AM	0.00
7/15/2015	8:30:00 AM	0.00
7/15/2015	8:45:00 AM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/15/2015	9:00:00 AM	0.00
7/15/2015	9:15:00 AM	0.00
7/15/2015	9:30:00 AM	0.00
7/15/2015	9:45:00 AM	0.00
7/15/2015	10:00:00 AM	0.00
7/15/2015	10:15:00 AM	0.00
7/15/2015	10:30:00 AM	0.00
7/15/2015	10:45:00 AM	0.29
7/15/2015	11:00:00 AM	0.49
7/15/2015	11:15:00 AM	0.51
7/15/2015	11:30:00 AM	0.52
7/15/2015	11:45:00 AM	0.52
7/15/2015	12:00:00 PM	0.53
7/15/2015	12:15:00 PM	0.53
7/15/2015	12:30:00 PM	0.54
7/15/2015	12:45:00 PM	0.54
7/15/2015	1:00:00 PM	0.57
7/15/2015	1:15:00 PM	0.59
7/15/2015	1:30:00 PM	0.59
7/15/2015	1:45:00 PM	0.58
7/15/2015	2:00:00 PM	0.58
7/15/2015	2:15:00 PM	0.56
7/15/2015	2:30:00 PM	0.50
7/15/2015	2:45:00 PM	0.42
7/15/2015	3:00:00 PM	0.35
7/15/2015	3:15:00 PM	0.26
7/15/2015	3:30:00 PM	0.20
7/15/2015	3:45:00 PM	0.16
7/15/2015	4:00:00 PM	0.13
7/15/2015	4:15:00 PM	0.11
7/15/2015	4:30:00 PM	0.09
7/15/2015	4:45:00 PM	0.08
7/15/2015	5:00:00 PM	0.07
7/15/2015	5:15:00 PM	0.06
7/15/2015	5:30:00 PM	0.05
7/15/2015	5:45:00 PM	0.05
7/15/2015	6:00:00 PM	0.04
7/15/2015	6:15:00 PM	0.04
7/15/2015	6:30:00 PM	0.04
7/15/2015	6:45:00 PM	0.03
7/15/2015	7:00:00 PM	0.03
7/15/2015	7:15:00 PM	0.02
7/15/2015	7:30:00 PM	0.00
7/15/2015	7:45:00 PM	0.00
7/15/2015	8:00:00 PM	0.00
7/15/2015	8:15:00 PM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/15/2015	8:30:00 PM	0.00
7/15/2015	8:45:00 PM	0.00
7/15/2015	9:00:00 PM	0.00
7/15/2015	9:15:00 PM	0.00
7/15/2015	9:30:00 PM	0.00
7/15/2015	9:45:00 PM	0.00
7/15/2015	10:00:00 PM	0.00
7/15/2015	10:15:00 PM	0.00
7/15/2015	10:30:00 PM	0.00
7/15/2015	10:45:00 PM	0.00
7/15/2015	11:00:00 PM	0.00
7/15/2015	11:15:00 PM	0.00
7/15/2015	11:30:00 PM	0.00
7/15/2015	11:45:00 PM	0.00
7/16/2015	12:00:00 AM	0.00
7/16/2015	12:15:00 AM	0.00
7/16/2015	12:30:00 AM	0.00
7/16/2015	12:45:00 AM	0.00
7/16/2015	1:00:00 AM	0.00
7/16/2015	1:15:00 AM	0.00
7/16/2015	1:30:00 AM	0.00
7/16/2015	1:45:00 AM	0.00
7/16/2015	2:00:00 AM	0.00
7/16/2015	2:15:00 AM	0.00
7/16/2015	2:30:00 AM	0.00
7/16/2015	2:45:00 AM	0.00
7/16/2015	3:00:00 AM	0.00
7/16/2015	3:15:00 AM	0.00
7/16/2015	3:30:00 AM	0.00
7/16/2015	3:45:00 AM	0.00
7/16/2015	4:00:00 AM	0.00
7/16/2015	4:15:00 AM	0.00
7/16/2015	4:30:00 AM	0.00
7/16/2015	4:45:00 AM	0.00
7/16/2015	5:00:00 AM	0.00
7/16/2015	5:15:00 AM	0.00
7/16/2015	5:30:00 AM	0.00
7/16/2015	5:45:00 AM	0.00
7/16/2015	6:00:00 AM	0.00
7/16/2015	6:15:00 AM	0.00
7/16/2015	6:30:00 AM	0.00
7/16/2015	6:45:00 AM	0.00
7/16/2015	7:00:00 AM	0.00
7/16/2015	7:15:00 AM	0.00
7/16/2015	7:30:00 AM	0.00
7/16/2015	7:45:00 AM	0.00

Locust Ditch Return Gage

DATE	TIME	GAGE
7/16/2015	8:00:00 AM	0.00
7/16/2015	8:15:00 AM	0.00
7/16/2015	8:30:00 AM	0.51
7/16/2015	8:45:00 AM	0.65
7/16/2015	9:00:00 AM	0.65
7/16/2015	9:15:00 AM	0.65
7/16/2015	9:30:00 AM	0.73
7/16/2015	9:45:00 AM	0.71
7/16/2015	10:00:00 AM	0.68
7/16/2015	10:15:00 AM	0.69
7/16/2015	10:30:00 AM	0.68
7/16/2015	10:45:00 AM	0.73
7/16/2015	11:00:00 AM	0.81
7/16/2015	11:15:00 AM	0.78
7/16/2015	11:30:00 AM	0.68
7/16/2015	11:45:00 AM	0.54
7/16/2015	12:00:00 PM	0.42
7/16/2015	12:15:00 PM	0.32
7/16/2015	12:30:00 PM	0.25
7/16/2015	12:45:00 PM	0.20
7/16/2015	1:00:00 PM	0.16
7/16/2015	1:15:00 PM	0.14
7/16/2015	1:30:00 PM	0.12
7/16/2015	1:45:00 PM	0.10
7/16/2015	2:00:00 PM	0.09
7/16/2015	2:15:00 PM	0.08
7/16/2015	2:30:00 PM	0.37
7/16/2015	2:45:00 PM	0.57
7/16/2015	3:00:00 PM	0.62
7/16/2015	3:15:00 PM	0.63
7/16/2015	3:30:00 PM	0.64
7/16/2015	3:45:00 PM	0.63
7/16/2015	4:00:00 PM	0.63
7/16/2015	4:15:00 PM	0.62
7/16/2015	4:30:00 PM	0.63
7/16/2015	4:45:00 PM	0.63
7/16/2015	5:00:00 PM	0.64
7/16/2015	5:15:00 PM	0.63
7/16/2015	5:30:00 PM	0.63
7/16/2015	5:45:00 PM	0.63
7/16/2015	6:00:00 PM	0.63
7/16/2015	6:15:00 PM	0.62
7/16/2015	6:30:00 PM	0.62
7/16/2015	6:45:00 PM	0.62
7/16/2015	7:00:00 PM	0.62
7/16/2015	7:15:00 PM	0.62

Locust Ditch Return Gage

DATE	TIME	GAGE
7/16/2015	7:30:00 PM	0.62
7/16/2015	7:45:00 PM	0.61
7/16/2015	8:00:00 PM	0.61
7/16/2015	8:15:00 PM	0.61
7/16/2015	8:30:00 PM	0.61
7/16/2015	8:45:00 PM	0.61
7/16/2015	9:00:00 PM	0.61
7/16/2015	9:15:00 PM	0.61
7/16/2015	9:30:00 PM	0.61
7/16/2015	9:45:00 PM	0.61
7/16/2015	10:00:00 PM	0.61
7/16/2015	10:15:00 PM	0.61
7/16/2015	10:30:00 PM	0.60
7/16/2015	10:45:00 PM	0.61
7/16/2015	11:00:00 PM	0.60
7/16/2015	11:15:00 PM	0.61
7/16/2015	11:30:00 PM	0.61
7/16/2015	11:45:00 PM	0.60
7/17/2015	12:00:00 AM	0.61
7/17/2015	12:15:00 AM	0.60
7/17/2015	12:30:00 AM	0.60
7/17/2015	12:45:00 AM	0.61
7/17/2015	1:00:00 AM	0.60
7/17/2015	1:15:00 AM	0.61
7/17/2015	1:30:00 AM	0.60
7/17/2015	1:45:00 AM	0.61
7/17/2015	2:00:00 AM	0.60
7/17/2015	2:15:00 AM	0.60
7/17/2015	2:30:00 AM	0.60
7/17/2015	2:45:00 AM	0.60
7/17/2015	3:00:00 AM	0.60
7/17/2015	3:15:00 AM	0.59
7/17/2015	3:30:00 AM	0.60
7/17/2015	3:45:00 AM	0.60
7/17/2015	4:00:00 AM	0.59
7/17/2015	4:15:00 AM	0.60
7/17/2015	4:30:00 AM	0.60
7/17/2015	4:45:00 AM	0.60
7/17/2015	5:00:00 AM	0.60
7/17/2015	5:15:00 AM	0.60
7/17/2015	5:30:00 AM	0.60
7/17/2015	5:45:00 AM	0.60
7/17/2015	6:00:00 AM	0.60
7/17/2015	6:15:00 AM	0.60
7/17/2015	6:30:00 AM	0.60
7/17/2015	6:45:00 AM	0.60

Locust Ditch Return Gage

DATE	TIME	GAGE
7/17/2015	7:00:00 AM	0.60
7/17/2015	7:15:00 AM	0.59
7/17/2015	7:30:00 AM	0.60
7/17/2015	7:45:00 AM	0.60
7/17/2015	8:00:00 AM	0.60
7/17/2015	8:15:00 AM	0.66
7/17/2015	8:30:00 AM	0.63
7/17/2015	8:45:00 AM	0.61
7/17/2015	9:00:00 AM	0.59
7/17/2015	9:15:00 AM	0.61
7/17/2015	9:30:00 AM	0.60
7/17/2015	9:45:00 AM	0.61
7/17/2015	10:00:00 AM	0.60
7/17/2015	10:15:00 AM	0.60
7/17/2015	10:30:00 AM	0.60
7/17/2015	10:45:00 AM	0.58
7/17/2015	11:00:00 AM	0.49
7/17/2015	11:15:00 AM	0.43
7/17/2015	11:30:00 AM	0.51
7/17/2015	11:45:00 AM	0.57
7/17/2015	12:00:00 PM	0.59
7/17/2015	12:15:00 PM	0.58
7/17/2015	12:30:00 PM	0.57
7/17/2015	12:45:00 PM	0.56
7/17/2015	1:00:00 PM	0.56
7/17/2015	1:15:00 PM	0.56
7/17/2015	1:30:00 PM	0.56
7/17/2015	1:45:00 PM	0.55
7/17/2015	2:00:00 PM	0.55
7/17/2015	2:15:00 PM	0.58
7/17/2015	2:30:00 PM	0.57
7/17/2015	2:45:00 PM	0.56
7/17/2015	3:00:00 PM	0.56
7/17/2015	3:15:00 PM	0.56
7/17/2015	3:30:00 PM	0.56
7/17/2015	3:45:00 PM	0.57
7/17/2015	4:00:00 PM	0.56
7/17/2015	4:15:00 PM	0.56
7/17/2015	4:30:00 PM	0.56
7/17/2015	4:45:00 PM	0.56
7/17/2015	5:00:00 PM	0.56
7/17/2015	5:15:00 PM	0.56
7/17/2015	5:30:00 PM	0.56
7/17/2015	5:45:00 PM	0.56
7/17/2015	6:00:00 PM	0.56
7/17/2015	6:15:00 PM	0.56

Locust Ditch Return Gage

DATE	TIME	GAGE
7/17/2015	6:30:00 PM	0.56
7/17/2015	6:45:00 PM	0.56
7/17/2015	7:00:00 PM	0.55
7/17/2015	7:15:00 PM	0.56
7/17/2015	7:30:00 PM	0.55
7/17/2015	7:45:00 PM	0.56
7/17/2015	8:00:00 PM	0.56
7/17/2015	8:15:00 PM	0.55
7/17/2015	8:30:00 PM	0.56
7/17/2015	8:45:00 PM	0.56
7/17/2015	9:00:00 PM	0.56
7/17/2015	9:15:00 PM	0.56
7/17/2015	9:30:00 PM	0.56
7/17/2015	9:45:00 PM	0.56
7/17/2015	10:00:00 PM	0.56
7/17/2015	10:15:00 PM	0.56
7/17/2015	10:30:00 PM	0.56
7/17/2015	10:45:00 PM	0.56
7/17/2015	11:00:00 PM	0.56
7/17/2015	11:15:00 PM	0.56
7/17/2015	11:30:00 PM	0.56
7/17/2015	11:45:00 PM	0.56
7/18/2015	12:00:00 AM	0.55
7/18/2015	12:15:00 AM	0.56
7/18/2015	12:30:00 AM	0.56
7/18/2015	12:45:00 AM	0.56
7/18/2015	1:00:00 AM	0.56
7/18/2015	1:15:00 AM	0.56
7/18/2015	1:30:00 AM	0.56
7/18/2015	1:45:00 AM	0.57
7/18/2015	2:00:00 AM	0.56
7/18/2015	2:15:00 AM	0.56
7/18/2015	2:30:00 AM	0.56
7/18/2015	2:45:00 AM	0.55
7/18/2015	3:00:00 AM	0.56
7/18/2015	3:15:00 AM	0.56
7/18/2015	3:30:00 AM	0.57
7/18/2015	3:45:00 AM	0.56
7/18/2015	4:00:00 AM	0.56
7/18/2015	4:15:00 AM	0.56
7/18/2015	4:30:00 AM	0.56
7/18/2015	4:45:00 AM	0.56
7/18/2015	5:00:00 AM	0.56
7/18/2015	5:15:00 AM	0.56
7/18/2015	5:30:00 AM	0.56
7/18/2015	5:45:00 AM	0.56

Locust Ditch Return Gage

DATE	TIME	GAGE
7/18/2015	6:00:00 AM	0.56
7/18/2015	6:15:00 AM	0.57
7/18/2015	6:30:00 AM	0.56
7/18/2015	6:45:00 AM	0.56
7/18/2015	7:00:00 AM	0.56
7/18/2015	7:15:00 AM	0.56
7/18/2015	7:30:00 AM	0.57
7/18/2015	7:45:00 AM	0.56
7/18/2015	8:00:00 AM	0.57
7/18/2015	8:15:00 AM	0.56
7/18/2015	8:30:00 AM	0.56
7/18/2015	8:45:00 AM	0.56
7/18/2015	9:00:00 AM	0.57
7/18/2015	9:15:00 AM	0.56
7/18/2015	9:30:00 AM	0.56
7/18/2015	9:45:00 AM	0.56
7/18/2015	10:00:00 AM	0.56
7/18/2015	10:15:00 AM	0.56
7/18/2015	10:30:00 AM	0.57
7/18/2015	10:45:00 AM	0.56
7/18/2015	11:00:00 AM	0.56
7/18/2015	11:15:00 AM	0.56
7/18/2015	11:30:00 AM	0.56
7/18/2015	11:45:00 AM	0.56
7/18/2015	12:00:00 PM	0.56
7/18/2015	12:15:00 PM	0.57
7/18/2015	12:30:00 PM	0.56
7/18/2015	12:45:00 PM	0.56
7/18/2015	1:00:00 PM	0.57
7/18/2015	1:15:00 PM	0.57
7/18/2015	1:30:00 PM	0.56
7/18/2015	1:45:00 PM	0.56
7/18/2015	2:00:00 PM	0.56
7/18/2015	2:15:00 PM	0.56
7/18/2015	2:30:00 PM	0.56
7/18/2015	2:45:00 PM	0.56
7/18/2015	3:00:00 PM	0.56
7/18/2015	3:15:00 PM	0.57
7/18/2015	3:30:00 PM	0.56
7/18/2015	3:45:00 PM	0.56
7/18/2015	4:00:00 PM	0.56
7/18/2015	4:15:00 PM	0.55
7/18/2015	4:30:00 PM	0.56
7/18/2015	4:45:00 PM	0.56
7/18/2015	5:00:00 PM	0.56
7/18/2015	5:15:00 PM	0.56

Locust Ditch Return Gage

DATE	TIME	GAGE
7/18/2015	5:30:00 PM	0.56
7/18/2015	5:45:00 PM	0.56
7/18/2015	6:00:00 PM	0.56
7/18/2015	6:15:00 PM	0.56
7/18/2015	6:30:00 PM	0.56
7/18/2015	6:45:00 PM	0.56
7/18/2015	7:00:00 PM	0.56
7/18/2015	7:15:00 PM	0.56
7/18/2015	7:30:00 PM	0.56
7/18/2015	7:45:00 PM	0.56
7/18/2015	8:00:00 PM	0.56
7/18/2015	8:15:00 PM	0.56
7/18/2015	8:30:00 PM	0.55
7/18/2015	8:45:00 PM	0.56
7/18/2015	9:00:00 PM	0.56
7/18/2015	9:15:00 PM	0.56
7/18/2015	9:30:00 PM	0.56
7/18/2015	9:45:00 PM	0.57
7/18/2015	10:00:00 PM	0.56
7/18/2015	10:15:00 PM	0.56
7/18/2015	10:30:00 PM	0.56
7/18/2015	10:45:00 PM	0.56
7/18/2015	11:00:00 PM	0.56
7/18/2015	11:15:00 PM	0.56
7/18/2015	11:30:00 PM	0.56
7/18/2015	11:45:00 PM	0.57
7/19/2015	12:00:00 AM	0.57
7/19/2015	12:15:00 AM	0.56
7/19/2015	12:30:00 AM	0.56
7/19/2015	12:45:00 AM	0.57
7/19/2015	1:00:00 AM	0.58
7/19/2015	1:15:00 AM	0.58
7/19/2015	1:30:00 AM	0.58
7/19/2015	1:45:00 AM	0.58
7/19/2015	2:00:00 AM	0.58
7/19/2015	2:15:00 AM	0.58
7/19/2015	2:30:00 AM	0.58
7/19/2015	2:45:00 AM	0.58
7/19/2015	3:00:00 AM	0.58
7/19/2015	3:15:00 AM	0.58
7/19/2015	3:30:00 AM	0.58
7/19/2015	3:45:00 AM	0.58
7/19/2015	4:00:00 AM	0.58
7/19/2015	4:15:00 AM	0.58
7/19/2015	4:30:00 AM	0.58
7/19/2015	4:45:00 AM	0.58

Locust Ditch Return Gage

DATE	TIME	GAGE
7/19/2015	5:00:00 AM	0.58
7/19/2015	5:15:00 AM	0.58
7/19/2015	5:30:00 AM	0.58
7/19/2015	5:45:00 AM	0.59
7/19/2015	6:00:00 AM	0.58
7/19/2015	6:15:00 AM	0.58
7/19/2015	6:30:00 AM	0.58
7/19/2015	6:45:00 AM	0.58
7/19/2015	7:00:00 AM	0.58
7/19/2015	7:15:00 AM	0.58
7/19/2015	7:30:00 AM	0.58
7/19/2015	7:45:00 AM	0.58
7/19/2015	8:00:00 AM	0.58
7/19/2015	8:15:00 AM	0.58
7/19/2015	8:30:00 AM	0.59
7/19/2015	8:45:00 AM	0.58
7/19/2015	9:00:00 AM	0.58
7/19/2015	9:15:00 AM	0.58
7/19/2015	9:30:00 AM	0.59
7/19/2015	9:45:00 AM	0.58
7/19/2015	10:00:00 AM	0.58
7/19/2015	10:15:00 AM	0.58
7/19/2015	10:30:00 AM	0.58
7/19/2015	10:45:00 AM	0.58
7/19/2015	11:00:00 AM	0.59
7/19/2015	11:15:00 AM	0.59
7/19/2015	11:30:00 AM	0.58
7/19/2015	11:45:00 AM	0.58
7/19/2015	12:00:00 PM	0.58
7/19/2015	12:15:00 PM	0.58
7/19/2015	12:30:00 PM	0.58
7/19/2015	12:45:00 PM	0.58
7/19/2015	1:00:00 PM	0.58
7/19/2015	1:15:00 PM	0.58
7/19/2015	1:30:00 PM	0.59
7/19/2015	1:45:00 PM	0.58
7/19/2015	2:00:00 PM	0.59
7/19/2015	2:15:00 PM	0.56
7/19/2015	2:30:00 PM	0.56
7/19/2015	2:45:00 PM	0.57
7/19/2015	3:00:00 PM	0.56
7/19/2015	3:15:00 PM	0.57
7/19/2015	3:30:00 PM	0.57
7/19/2015	3:45:00 PM	0.57
7/19/2015	4:00:00 PM	0.57
7/19/2015	4:15:00 PM	0.56

Locust Ditch Return Gage

DATE	TIME	GAGE
7/19/2015	4:30:00 PM	0.57
7/19/2015	4:45:00 PM	0.57
7/19/2015	5:00:00 PM	0.57
7/19/2015	5:15:00 PM	0.58
7/19/2015	5:30:00 PM	0.57
7/19/2015	5:45:00 PM	0.57
7/19/2015	6:00:00 PM	0.57
7/19/2015	6:15:00 PM	0.57
7/19/2015	6:30:00 PM	0.56
7/19/2015	6:45:00 PM	0.57
7/19/2015	7:00:00 PM	0.57
7/19/2015	7:15:00 PM	0.57
7/19/2015	7:30:00 PM	0.57
7/19/2015	7:45:00 PM	0.56
7/19/2015	8:00:00 PM	0.57
7/19/2015	8:15:00 PM	0.56
7/19/2015	8:30:00 PM	0.57
7/19/2015	8:45:00 PM	0.57
7/19/2015	9:00:00 PM	0.57
7/19/2015	9:15:00 PM	0.57
7/19/2015	9:30:00 PM	0.57
7/19/2015	9:45:00 PM	0.57
7/19/2015	10:00:00 PM	0.57
7/19/2015	10:15:00 PM	0.57
7/19/2015	10:30:00 PM	0.57
7/19/2015	10:45:00 PM	0.57
7/19/2015	11:00:00 PM	0.57
7/19/2015	11:15:00 PM	0.57
7/19/2015	11:30:00 PM	0.57
7/19/2015	11:45:00 PM	0.57
7/20/2015	12:00:00 AM	0.57
7/20/2015	12:15:00 AM	0.57
7/20/2015	12:30:00 AM	0.57
7/20/2015	12:45:00 AM	0.57
7/20/2015	1:00:00 AM	0.57
7/20/2015	1:15:00 AM	0.57
7/20/2015	1:30:00 AM	0.57
7/20/2015	1:45:00 AM	0.57
7/20/2015	2:00:00 AM	0.57
7/20/2015	2:15:00 AM	0.57
7/20/2015	2:30:00 AM	0.57
7/20/2015	2:45:00 AM	0.57
7/20/2015	3:00:00 AM	0.56
7/20/2015	3:15:00 AM	0.57
7/20/2015	3:30:00 AM	0.57
7/20/2015	3:45:00 AM	0.57

Locust Ditch Return Gage

DATE	TIME	GAGE
7/20/2015	4:00:00 AM	0.57
7/20/2015	4:15:00 AM	0.57
7/20/2015	4:30:00 AM	0.57
7/20/2015	4:45:00 AM	0.57
7/20/2015	5:00:00 AM	0.57
7/20/2015	5:15:00 AM	0.57
7/20/2015	5:30:00 AM	0.57
7/20/2015	5:45:00 AM	0.57
7/20/2015	6:00:00 AM	0.57
7/20/2015	6:15:00 AM	0.57
7/20/2015	6:30:00 AM	0.57
7/20/2015	6:45:00 AM	0.57
7/20/2015	7:00:00 AM	0.57
7/20/2015	7:15:00 AM	0.57
7/20/2015	7:30:00 AM	0.57
7/20/2015	7:45:00 AM	0.57
7/20/2015	8:00:00 AM	0.57
7/20/2015	8:15:00 AM	0.57
7/20/2015	8:30:00 AM	0.57
7/20/2015	8:45:00 AM	0.58
7/20/2015	9:00:00 AM	0.57
7/20/2015	9:15:00 AM	0.57
7/20/2015	9:30:00 AM	0.57
7/20/2015	9:45:00 AM	0.58
7/20/2015	10:00:00 AM	0.58
7/20/2015	10:15:00 AM	0.57
7/20/2015	10:30:00 AM	0.58
7/20/2015	10:45:00 AM	0.58
7/20/2015	11:00:00 AM	0.58
7/20/2015	11:15:00 AM	0.58
7/20/2015	11:30:00 AM	0.57
7/20/2015	11:45:00 AM	0.58
7/20/2015	12:00:00 PM	0.58
7/20/2015	12:15:00 PM	0.57
7/20/2015	12:30:00 PM	0.57
7/20/2015	12:45:00 PM	0.58
7/20/2015	1:00:00 PM	0.57
7/20/2015	1:15:00 PM	0.58
7/20/2015	1:30:00 PM	0.58
7/20/2015	1:45:00 PM	0.57
7/20/2015	2:00:00 PM	0.58
7/20/2015	2:15:00 PM	0.58
7/20/2015	2:30:00 PM	0.57
7/20/2015	2:45:00 PM	0.57
7/20/2015	3:00:00 PM	0.58
7/20/2015	3:15:00 PM	0.57

Locust Ditch Return Gage

DATE	TIME	GAGE
7/20/2015	3:30:00 PM	0.58
7/20/2015	3:45:00 PM	0.57
7/20/2015	4:00:00 PM	0.58
7/20/2015	4:15:00 PM	0.58
7/20/2015	4:30:00 PM	0.57
7/20/2015	4:45:00 PM	0.57
7/20/2015	5:00:00 PM	0.58
7/20/2015	5:15:00 PM	0.57
7/20/2015	5:30:00 PM	0.58
7/20/2015	5:45:00 PM	0.58
7/20/2015	6:00:00 PM	0.58
7/20/2015	6:15:00 PM	0.58
7/20/2015	6:30:00 PM	0.57
7/20/2015	6:45:00 PM	0.58
7/20/2015	7:00:00 PM	0.58
7/20/2015	7:15:00 PM	0.57
7/20/2015	7:30:00 PM	0.58
7/20/2015	7:45:00 PM	0.58
7/20/2015	8:00:00 PM	0.57
7/20/2015	8:15:00 PM	0.58
7/20/2015	8:30:00 PM	0.57
7/20/2015	8:45:00 PM	0.58
7/20/2015	9:00:00 PM	0.58
7/20/2015	9:15:00 PM	0.58
7/20/2015	9:30:00 PM	0.58
7/20/2015	9:45:00 PM	0.58
7/20/2015	10:00:00 PM	0.58
7/20/2015	10:15:00 PM	0.58
7/20/2015	10:30:00 PM	0.58
7/20/2015	10:45:00 PM	0.58
7/20/2015	11:00:00 PM	0.58
7/20/2015	11:15:00 PM	0.58
7/20/2015	11:30:00 PM	0.58
7/20/2015	11:45:00 PM	0.58
7/21/2015	12:00:00 AM	0.58
7/21/2015	12:15:00 AM	0.58
7/21/2015	12:30:00 AM	0.58
7/21/2015	12:45:00 AM	0.58
7/21/2015	1:00:00 AM	0.58
7/21/2015	1:15:00 AM	0.58
7/21/2015	1:30:00 AM	0.58
7/21/2015	1:45:00 AM	0.58
7/21/2015	2:00:00 AM	0.58
7/21/2015	2:15:00 AM	0.58
7/21/2015	2:30:00 AM	0.58
7/21/2015	2:45:00 AM	0.58

Locust Ditch Return Gage

DATE	TIME	GAGE
7/21/2015	3:00:00 AM	0.58
7/21/2015	3:15:00 AM	0.58
7/21/2015	3:30:00 AM	0.58
7/21/2015	3:45:00 AM	0.58
7/21/2015	4:00:00 AM	0.58
7/21/2015	4:15:00 AM	0.58
7/21/2015	4:30:00 AM	0.58
7/21/2015	4:45:00 AM	0.58
7/21/2015	5:00:00 AM	0.58
7/21/2015	5:15:00 AM	0.58
7/21/2015	5:30:00 AM	0.58
7/21/2015	5:45:00 AM	0.58
7/21/2015	6:00:00 AM	0.58
7/21/2015	6:15:00 AM	0.58
7/21/2015	6:30:00 AM	0.58
7/21/2015	6:45:00 AM	0.58
7/21/2015	7:00:00 AM	0.58
7/21/2015	7:15:00 AM	0.58
7/21/2015	7:30:00 AM	0.58
7/21/2015	7:45:00 AM	0.58
7/21/2015	8:00:00 AM	0.58
7/21/2015	8:15:00 AM	0.58
7/21/2015	8:30:00 AM	0.58
7/21/2015	8:45:00 AM	0.58
7/21/2015	9:00:00 AM	0.58
7/21/2015	9:15:00 AM	0.58
7/21/2015	9:30:00 AM	0.58
7/21/2015	9:45:00 AM	0.58
7/21/2015	10:00:00 AM	0.58
7/21/2015	10:15:00 AM	0.59
7/21/2015	10:30:00 AM	0.58
7/21/2015	10:45:00 AM	0.59
7/21/2015	11:00:00 AM	0.58
7/21/2015	11:15:00 AM	0.57
7/21/2015	11:30:00 AM	0.57
7/21/2015	11:45:00 AM	0.56
7/21/2015	12:00:00 PM	0.55
7/21/2015	12:15:00 PM	0.55
7/21/2015	12:30:00 PM	0.55
7/21/2015	12:45:00 PM	0.54
7/21/2015	1:00:00 PM	0.54
7/21/2015	1:15:00 PM	0.54
7/21/2015	1:30:00 PM	0.55
7/21/2015	1:45:00 PM	0.55
7/21/2015	2:00:00 PM	0.55
7/21/2015	2:15:00 PM	0.55

Locust Ditch Return Gage

DATE	TIME	GAGE
7/21/2015	2:30:00 PM	0.55
7/21/2015	2:45:00 PM	0.55
7/21/2015	3:00:00 PM	0.55
7/21/2015	3:15:00 PM	0.56
7/21/2015	3:30:00 PM	0.55
7/21/2015	3:45:00 PM	0.56
7/21/2015	4:00:00 PM	0.56
7/21/2015	4:15:00 PM	0.55
7/21/2015	4:30:00 PM	0.56
7/21/2015	4:45:00 PM	0.56
7/21/2015	5:00:00 PM	0.56
7/21/2015	5:15:00 PM	0.56
7/21/2015	5:30:00 PM	0.56
7/21/2015	5:45:00 PM	0.56
7/21/2015	6:00:00 PM	0.56
7/21/2015	6:15:00 PM	0.57
7/21/2015	6:30:00 PM	0.56
7/21/2015	6:45:00 PM	0.56
7/21/2015	7:00:00 PM	0.56
7/21/2015	7:15:00 PM	0.57
7/21/2015	7:30:00 PM	0.56
7/21/2015	7:45:00 PM	0.57
7/21/2015	8:00:00 PM	0.57
7/21/2015	8:15:00 PM	0.57
7/21/2015	8:30:00 PM	0.56
7/21/2015	8:45:00 PM	0.57
7/21/2015	9:00:00 PM	0.57
7/21/2015	9:15:00 PM	0.56
7/21/2015	9:30:00 PM	0.57
7/21/2015	9:45:00 PM	0.57
7/21/2015	10:00:00 PM	0.57
7/21/2015	10:15:00 PM	0.57
7/21/2015	10:30:00 PM	0.57
7/21/2015	10:45:00 PM	0.57
7/21/2015	11:00:00 PM	0.57
7/21/2015	11:15:00 PM	0.57
7/21/2015	11:30:00 PM	0.57
7/21/2015	11:45:00 PM	0.57
7/22/2015	12:00:00 AM	0.57
7/22/2015	12:15:00 AM	0.57
7/22/2015	12:30:00 AM	0.58
7/22/2015	12:45:00 AM	0.57
7/22/2015	1:00:00 AM	0.57
7/22/2015	1:15:00 AM	0.57
7/22/2015	1:30:00 AM	0.57
7/22/2015	1:45:00 AM	0.57

Locust Ditch Return Gage

DATE	TIME	GAGE
7/22/2015	2:00:00 AM	0.58
7/22/2015	2:15:00 AM	0.58
7/22/2015	2:30:00 AM	0.57
7/22/2015	2:45:00 AM	0.57
7/22/2015	3:00:00 AM	0.58
7/22/2015	3:15:00 AM	0.58
7/22/2015	3:30:00 AM	0.57
7/22/2015	3:45:00 AM	0.57
7/22/2015	4:00:00 AM	0.58
7/22/2015	4:15:00 AM	0.57
7/22/2015	4:30:00 AM	0.58
7/22/2015	4:45:00 AM	0.57
7/22/2015	5:00:00 AM	0.58
7/22/2015	5:15:00 AM	0.58
7/22/2015	5:30:00 AM	0.58
7/22/2015	5:45:00 AM	0.58
7/22/2015	6:00:00 AM	0.58
7/22/2015	6:15:00 AM	0.58
7/22/2015	6:30:00 AM	0.58
7/22/2015	6:45:00 AM	0.58
7/22/2015	7:00:00 AM	0.58
7/22/2015	7:15:00 AM	0.58
7/22/2015	7:30:00 AM	0.58
7/22/2015	7:45:00 AM	0.58
7/22/2015	8:00:00 AM	0.58
7/22/2015	8:15:00 AM	0.58
7/22/2015	8:30:00 AM	0.58
7/22/2015	8:45:00 AM	0.58
7/22/2015	9:00:00 AM	0.58
7/22/2015	9:15:00 AM	0.58
7/22/2015	9:30:00 AM	0.58
7/22/2015	9:45:00 AM	0.58
7/22/2015	10:00:00 AM	0.59
7/22/2015	10:15:00 AM	0.58
7/22/2015	10:30:00 AM	0.58
7/22/2015	10:45:00 AM	0.58
7/22/2015	11:00:00 AM	0.58
7/22/2015	11:15:00 AM	0.58
7/22/2015	11:30:00 AM	0.58
7/22/2015	11:45:00 AM	0.58
7/22/2015	12:00:00 PM	0.59
7/22/2015	12:15:00 PM	0.58
7/22/2015	12:30:00 PM	0.58
7/22/2015	12:45:00 PM	0.57
7/22/2015	1:00:00 PM	0.59
7/22/2015	1:15:00 PM	0.60

Locust Ditch Return Gage

DATE	TIME	GAGE
7/22/2015	1:30:00 PM	0.60
7/22/2015	1:45:00 PM	0.60
7/22/2015	2:00:00 PM	0.60
7/22/2015	2:15:00 PM	0.61
7/22/2015	2:30:00 PM	0.60
7/22/2015	2:45:00 PM	0.60
7/22/2015	3:00:00 PM	0.60
7/22/2015	3:15:00 PM	0.60
7/22/2015	3:30:00 PM	0.59
7/22/2015	3:45:00 PM	0.60
7/22/2015	4:00:00 PM	0.60
7/22/2015	4:15:00 PM	0.60
7/22/2015	4:30:00 PM	0.60
7/22/2015	4:45:00 PM	0.60
7/22/2015	5:00:00 PM	0.61
7/22/2015	5:15:00 PM	0.60
7/22/2015	5:30:00 PM	0.61
7/22/2015	5:45:00 PM	0.60
7/22/2015	6:00:00 PM	0.60
7/22/2015	6:15:00 PM	0.60
7/22/2015	6:30:00 PM	0.60
7/22/2015	6:45:00 PM	0.60
7/22/2015	7:00:00 PM	0.61
7/22/2015	7:15:00 PM	0.60
7/22/2015	7:30:00 PM	0.60
7/22/2015	7:45:00 PM	0.60
7/22/2015	8:00:00 PM	0.60
7/22/2015	8:15:00 PM	0.61
7/22/2015	8:30:00 PM	0.61
7/22/2015	8:45:00 PM	0.60
7/22/2015	9:00:00 PM	0.61
7/22/2015	9:15:00 PM	0.61
7/22/2015	9:30:00 PM	0.61
7/22/2015	9:45:00 PM	0.61
7/22/2015	10:00:00 PM	0.61
7/22/2015	10:15:00 PM	0.61
7/22/2015	10:30:00 PM	0.61
7/22/2015	10:45:00 PM	0.61
7/22/2015	11:00:00 PM	0.60
7/22/2015	11:15:00 PM	0.61
7/22/2015	11:30:00 PM	0.61
7/22/2015	11:45:00 PM	0.61
7/23/2015	12:00:00 AM	0.60
7/23/2015	12:15:00 AM	0.61
7/23/2015	12:30:00 AM	0.61
7/23/2015	12:45:00 AM	0.61

Locust Ditch Return Gage

DATE	TIME	GAGE
7/23/2015	1:00:00 AM	0.61
7/23/2015	1:15:00 AM	0.61
7/23/2015	1:30:00 AM	0.61
7/23/2015	1:45:00 AM	0.61
7/23/2015	2:00:00 AM	0.61
7/23/2015	2:15:00 AM	0.61
7/23/2015	2:30:00 AM	0.61
7/23/2015	2:45:00 AM	0.60
7/23/2015	3:00:00 AM	0.62
7/23/2015	3:15:00 AM	0.61
7/23/2015	3:30:00 AM	0.61
7/23/2015	3:45:00 AM	0.61
7/23/2015	4:00:00 AM	0.61
7/23/2015	4:15:00 AM	0.60
7/23/2015	4:30:00 AM	0.61
7/23/2015	4:45:00 AM	0.61
7/23/2015	5:00:00 AM	0.61
7/23/2015	5:15:00 AM	0.61
7/23/2015	5:30:00 AM	0.61
7/23/2015	5:45:00 AM	0.61
7/23/2015	6:00:00 AM	0.61
7/23/2015	6:15:00 AM	0.61
7/23/2015	6:30:00 AM	0.61
7/23/2015	6:45:00 AM	0.61
7/23/2015	7:00:00 AM	0.61
7/23/2015	7:15:00 AM	0.61
7/23/2015	7:30:00 AM	0.61
7/23/2015	7:45:00 AM	0.61
7/23/2015	8:00:00 AM	0.61
7/23/2015	8:15:00 AM	0.61
7/23/2015	8:30:00 AM	0.61
7/23/2015	8:45:00 AM	0.61
7/23/2015	9:00:00 AM	0.61
7/23/2015	9:15:00 AM	0.61
7/23/2015	9:30:00 AM	0.61
7/23/2015	9:45:00 AM	0.61
7/23/2015	10:00:00 AM	0.62
7/23/2015	10:15:00 AM	0.61
7/23/2015	10:30:00 AM	0.61
7/23/2015	10:45:00 AM	0.62
7/23/2015	11:00:00 AM	0.61
7/23/2015	11:15:00 AM	0.61
7/23/2015	11:30:00 AM	0.61
7/23/2015	11:45:00 AM	0.61
7/23/2015	12:00:00 PM	0.61
7/23/2015	12:15:00 PM	0.61

Locust Ditch Return Gage

DATE	TIME	GAGE
7/23/2015	12:30:00 PM	0.61
7/23/2015	12:45:00 PM	0.61
7/23/2015	1:00:00 PM	0.61
7/23/2015	1:15:00 PM	0.61
7/23/2015	1:30:00 PM	0.61
7/23/2015	1:45:00 PM	0.62
7/23/2015	2:00:00 PM	0.61
7/23/2015	2:15:00 PM	0.61
7/23/2015	2:30:00 PM	0.61
7/23/2015	2:45:00 PM	0.62
7/23/2015	3:00:00 PM	0.64
7/23/2015	3:15:00 PM	0.64
7/23/2015	3:30:00 PM	0.64
7/23/2015	3:45:00 PM	0.64
7/23/2015	4:00:00 PM	0.64
7/23/2015	4:15:00 PM	0.64
7/23/2015	4:30:00 PM	0.64
7/23/2015	4:45:00 PM	0.64
7/23/2015	5:00:00 PM	0.64
7/23/2015	5:15:00 PM	0.63
7/23/2015	5:30:00 PM	0.64
7/23/2015	5:45:00 PM	0.64
7/23/2015	6:00:00 PM	0.64
7/23/2015	6:15:00 PM	0.64
7/23/2015	6:30:00 PM	0.64
7/23/2015	6:45:00 PM	0.63
7/23/2015	7:00:00 PM	0.63
7/23/2015	7:15:00 PM	0.64
7/23/2015	7:30:00 PM	0.64
7/23/2015	7:45:00 PM	0.63
7/23/2015	8:00:00 PM	0.64
7/23/2015	8:15:00 PM	0.63
7/23/2015	8:30:00 PM	0.64
7/23/2015	8:45:00 PM	0.63
7/23/2015	9:00:00 PM	0.64
7/23/2015	9:15:00 PM	0.64
7/23/2015	9:30:00 PM	0.64
7/23/2015	9:45:00 PM	0.64
7/23/2015	10:00:00 PM	0.64
7/23/2015	10:15:00 PM	0.64
7/23/2015	10:30:00 PM	0.64
7/23/2015	10:45:00 PM	0.64
7/23/2015	11:00:00 PM	0.64
7/23/2015	11:15:00 PM	0.64
7/23/2015	11:30:00 PM	0.64
7/23/2015	11:45:00 PM	0.64

Locust Ditch Return Gage

DATE	TIME	GAGE
7/24/2015	12:00:00 AM	0.64
7/24/2015	12:15:00 AM	0.64
7/24/2015	12:30:00 AM	0.64
7/24/2015	12:45:00 AM	0.64
7/24/2015	1:00:00 AM	0.64
7/24/2015	1:15:00 AM	0.64
7/24/2015	1:30:00 AM	0.64
7/24/2015	1:45:00 AM	0.64
7/24/2015	2:00:00 AM	0.64
7/24/2015	2:15:00 AM	0.64
7/24/2015	2:30:00 AM	0.64
7/24/2015	2:45:00 AM	0.64
7/24/2015	3:00:00 AM	0.65
7/24/2015	3:15:00 AM	0.65
7/24/2015	3:30:00 AM	0.63
7/24/2015	3:45:00 AM	0.64
7/24/2015	4:00:00 AM	0.64
7/24/2015	4:15:00 AM	0.63
7/24/2015	4:30:00 AM	0.64
7/24/2015	4:45:00 AM	0.64
7/24/2015	5:00:00 AM	0.64
7/24/2015	5:15:00 AM	0.64
7/24/2015	5:30:00 AM	0.64
7/24/2015	5:45:00 AM	0.64
7/24/2015	6:00:00 AM	0.64
7/24/2015	6:15:00 AM	0.65
7/24/2015	6:30:00 AM	0.65
7/24/2015	6:45:00 AM	0.64
7/24/2015	7:00:00 AM	0.64
7/24/2015	7:15:00 AM	0.64
7/24/2015	7:30:00 AM	0.64
7/24/2015	7:45:00 AM	0.64
7/24/2015	8:00:00 AM	0.64
7/24/2015	8:15:00 AM	0.64
7/24/2015	8:30:00 AM	0.64
7/24/2015	8:45:00 AM	0.64
7/24/2015	9:00:00 AM	0.64
7/24/2015	9:15:00 AM	0.64
7/24/2015	9:30:00 AM	0.64
7/24/2015	9:45:00 AM	0.65
7/24/2015	10:00:00 AM	0.64
7/24/2015	10:15:00 AM	0.64
7/24/2015	10:30:00 AM	0.64
7/24/2015	10:45:00 AM	0.64
7/24/2015	11:00:00 AM	0.64
7/24/2015	11:15:00 AM	0.64

Locust Ditch Return Gage

DATE	TIME	GAGE
7/24/2015	11:30:00 AM	0.64
7/24/2015	11:45:00 AM	0.64
7/24/2015	12:00:00 PM	0.64
7/24/2015	12:15:00 PM	0.63
7/24/2015	12:30:00 PM	0.64
7/24/2015	12:45:00 PM	0.64
7/24/2015	1:00:00 PM	0.64
7/24/2015	1:15:00 PM	0.64
7/24/2015	1:30:00 PM	0.64
7/24/2015	1:45:00 PM	0.65
7/24/2015	2:00:00 PM	0.66
7/24/2015	2:15:00 PM	0.65
7/24/2015	2:30:00 PM	0.66
7/24/2015	2:45:00 PM	0.66
7/24/2015	3:00:00 PM	0.66
7/24/2015	3:15:00 PM	0.66
7/24/2015	3:30:00 PM	0.66
7/24/2015	3:45:00 PM	0.66
7/24/2015	4:00:00 PM	0.66
7/24/2015	4:15:00 PM	0.65
7/24/2015	4:30:00 PM	0.66
7/24/2015	4:45:00 PM	0.65
7/24/2015	5:00:00 PM	0.66
7/24/2015	5:15:00 PM	0.66
7/24/2015	5:30:00 PM	0.66
7/24/2015	5:45:00 PM	0.66
7/24/2015	6:00:00 PM	0.66
7/24/2015	6:15:00 PM	0.65
7/24/2015	6:30:00 PM	0.65
7/24/2015	6:45:00 PM	0.65
7/24/2015	7:00:00 PM	0.65
7/24/2015	7:15:00 PM	0.66
7/24/2015	7:30:00 PM	0.65
7/24/2015	7:45:00 PM	0.66
7/24/2015	8:00:00 PM	0.66
7/24/2015	8:15:00 PM	0.66
7/24/2015	8:30:00 PM	0.65
7/24/2015	8:45:00 PM	0.66
7/24/2015	9:00:00 PM	0.66
7/24/2015	9:15:00 PM	0.66
7/24/2015	9:30:00 PM	0.66
7/24/2015	9:45:00 PM	0.66
7/24/2015	10:00:00 PM	0.66
7/24/2015	10:15:00 PM	0.65
7/24/2015	10:30:00 PM	0.66
7/24/2015	10:45:00 PM	0.66

Locust Ditch Return Gage

DATE	TIME	GAGE
7/24/2015	11:00:00 PM	0.65
7/24/2015	11:15:00 PM	0.66
7/24/2015	11:30:00 PM	0.66
7/24/2015	11:45:00 PM	0.66
7/25/2015	12:00:00 AM	0.66
7/25/2015	12:15:00 AM	0.66
7/25/2015	12:30:00 AM	0.66
7/25/2015	12:45:00 AM	0.66
7/25/2015	1:00:00 AM	0.65
7/25/2015	1:15:00 AM	0.66
7/25/2015	1:30:00 AM	0.65
7/25/2015	1:45:00 AM	0.66
7/25/2015	2:00:00 AM	0.66
7/25/2015	2:15:00 AM	0.67
7/25/2015	2:30:00 AM	0.65
7/25/2015	2:45:00 AM	0.66
7/25/2015	3:00:00 AM	0.66
7/25/2015	3:15:00 AM	0.67
7/25/2015	3:30:00 AM	0.66
7/25/2015	3:45:00 AM	0.66
7/25/2015	4:00:00 AM	0.66
7/25/2015	4:15:00 AM	0.66
7/25/2015	4:30:00 AM	0.66
7/25/2015	4:45:00 AM	0.66
7/25/2015	5:00:00 AM	0.66
7/25/2015	5:15:00 AM	0.66
7/25/2015	5:30:00 AM	0.66
7/25/2015	5:45:00 AM	0.66
7/25/2015	6:00:00 AM	0.67
7/25/2015	6:15:00 AM	0.66
7/25/2015	6:30:00 AM	0.66
7/25/2015	6:45:00 AM	0.66
7/25/2015	7:00:00 AM	0.66
7/25/2015	7:15:00 AM	0.65
7/25/2015	7:30:00 AM	0.66
7/25/2015	7:45:00 AM	0.66
7/25/2015	8:00:00 AM	0.66
7/25/2015	8:15:00 AM	0.67
7/25/2015	8:30:00 AM	0.66
7/25/2015	8:45:00 AM	0.66
7/25/2015	9:00:00 AM	0.66
7/25/2015	9:15:00 AM	0.66
7/25/2015	9:30:00 AM	0.66
7/25/2015	9:45:00 AM	0.66
7/25/2015	10:00:00 AM	0.66
7/25/2015	10:15:00 AM	0.66

Locust Ditch Return Gage

DATE	TIME	GAGE
7/25/2015	10:30:00 AM	0.66
7/25/2015	10:45:00 AM	0.66
7/25/2015	11:00:00 AM	0.66
7/25/2015	11:15:00 AM	0.66
7/25/2015	11:30:00 AM	0.66
7/25/2015	11:45:00 AM	0.66
7/25/2015	12:00:00 PM	0.66
7/25/2015	12:15:00 PM	0.66
7/25/2015	12:30:00 PM	0.66
7/25/2015	12:45:00 PM	0.66
7/25/2015	1:00:00 PM	0.66
7/25/2015	1:15:00 PM	0.67
7/25/2015	1:30:00 PM	0.66
7/25/2015	1:45:00 PM	0.66
7/25/2015	2:00:00 PM	0.66
7/25/2015	2:15:00 PM	0.66
7/25/2015	2:30:00 PM	0.66
7/25/2015	2:45:00 PM	0.66
7/25/2015	3:00:00 PM	0.66
7/25/2015	3:15:00 PM	0.66
7/25/2015	3:30:00 PM	0.66
7/25/2015	3:45:00 PM	0.65
7/25/2015	4:00:00 PM	0.66
7/25/2015	4:15:00 PM	0.65
7/25/2015	4:30:00 PM	0.66
7/25/2015	4:45:00 PM	0.66
7/25/2015	5:00:00 PM	0.65
7/25/2015	5:15:00 PM	0.65
7/25/2015	5:30:00 PM	0.66
7/25/2015	5:45:00 PM	0.66
7/25/2015	6:00:00 PM	0.66
7/25/2015	6:15:00 PM	0.65
7/25/2015	6:30:00 PM	0.65
7/25/2015	6:45:00 PM	0.65
7/25/2015	7:00:00 PM	0.66
7/25/2015	7:15:00 PM	0.66
7/25/2015	7:30:00 PM	0.66
7/25/2015	7:45:00 PM	0.66
7/25/2015	8:00:00 PM	0.66
7/25/2015	8:15:00 PM	0.66
7/25/2015	8:30:00 PM	0.66
7/25/2015	8:45:00 PM	0.66
7/25/2015	9:00:00 PM	0.65
7/25/2015	9:15:00 PM	0.66
7/25/2015	9:30:00 PM	0.65
7/25/2015	9:45:00 PM	0.66

Locust Ditch Return Gage

DATE	TIME	GAGE
7/25/2015	10:00:00 PM	0.66
7/25/2015	10:15:00 PM	0.66
7/25/2015	10:30:00 PM	0.66
7/25/2015	10:45:00 PM	0.66
7/25/2015	11:00:00 PM	0.66
7/25/2015	11:15:00 PM	0.66
7/25/2015	11:30:00 PM	0.66
7/25/2015	11:45:00 PM	0.66
7/26/2015	12:00:00 AM	0.66
7/26/2015	12:15:00 AM	0.65
7/26/2015	12:30:00 AM	0.66
7/26/2015	12:45:00 AM	0.66
7/26/2015	1:00:00 AM	0.66
7/26/2015	1:15:00 AM	0.66
7/26/2015	1:30:00 AM	0.66
7/26/2015	1:45:00 AM	0.65
7/26/2015	2:00:00 AM	0.66
7/26/2015	2:15:00 AM	0.66
7/26/2015	2:30:00 AM	0.66
7/26/2015	2:45:00 AM	0.66
7/26/2015	3:00:00 AM	0.66
7/26/2015	3:15:00 AM	0.66
7/26/2015	3:30:00 AM	0.66
7/26/2015	3:45:00 AM	0.66
7/26/2015	4:00:00 AM	0.66
7/26/2015	4:15:00 AM	0.66
7/26/2015	4:30:00 AM	0.66
7/26/2015	4:45:00 AM	0.66
7/26/2015	5:00:00 AM	0.65
7/26/2015	5:15:00 AM	0.66
7/26/2015	5:30:00 AM	0.65
7/26/2015	5:45:00 AM	0.66
7/26/2015	6:00:00 AM	0.66
7/26/2015	6:15:00 AM	0.66
7/26/2015	6:30:00 AM	0.66
7/26/2015	6:45:00 AM	0.66
7/26/2015	7:00:00 AM	0.66
7/26/2015	7:15:00 AM	0.66
7/26/2015	7:30:00 AM	0.65
7/26/2015	7:45:00 AM	0.66
7/26/2015	8:00:00 AM	0.66
7/26/2015	8:15:00 AM	0.66
7/26/2015	8:30:00 AM	0.66
7/26/2015	8:45:00 AM	0.66
7/26/2015	9:00:00 AM	0.66
7/26/2015	9:15:00 AM	0.66

Locust Ditch Return Gage

DATE	TIME	GAGE
7/26/2015	9:30:00 AM	0.66
7/26/2015	9:45:00 AM	0.66
7/26/2015	10:00:00 AM	0.66
7/26/2015	10:15:00 AM	0.67
7/26/2015	10:30:00 AM	0.66
7/26/2015	10:45:00 AM	0.66
7/26/2015	11:00:00 AM	0.66
7/26/2015	11:15:00 AM	0.66
7/26/2015	11:30:00 AM	0.66
7/26/2015	11:45:00 AM	0.66
7/26/2015	12:00:00 PM	0.66
7/26/2015	12:15:00 PM	0.66
7/26/2015	12:30:00 PM	0.66
7/26/2015	12:45:00 PM	0.66
7/26/2015	1:00:00 PM	0.66
7/26/2015	1:15:00 PM	0.66
7/26/2015	1:30:00 PM	0.65
7/26/2015	1:45:00 PM	0.66
7/26/2015	2:00:00 PM	0.66
7/26/2015	2:15:00 PM	0.66
7/26/2015	2:30:00 PM	0.66
7/26/2015	2:45:00 PM	0.65
7/26/2015	3:00:00 PM	0.66
7/26/2015	3:15:00 PM	0.66
7/26/2015	3:30:00 PM	0.66
7/26/2015	3:45:00 PM	0.66
7/26/2015	4:00:00 PM	0.66
7/26/2015	4:15:00 PM	0.66
7/26/2015	4:30:00 PM	0.66
7/26/2015	4:45:00 PM	0.66
7/26/2015	5:00:00 PM	0.65
7/26/2015	5:15:00 PM	0.66
7/26/2015	5:30:00 PM	0.66
7/26/2015	5:45:00 PM	0.66
7/26/2015	6:00:00 PM	0.66
7/26/2015	6:15:00 PM	0.65
7/26/2015	6:30:00 PM	0.65
7/26/2015	6:45:00 PM	0.66
7/26/2015	7:00:00 PM	0.66
7/26/2015	7:15:00 PM	0.66
7/26/2015	7:30:00 PM	0.66
7/26/2015	7:45:00 PM	0.66
7/26/2015	8:00:00 PM	0.65
7/26/2015	8:15:00 PM	0.66
7/26/2015	8:30:00 PM	0.66
7/26/2015	8:45:00 PM	0.66

Locust Ditch Return Gage

DATE	TIME	GAGE
7/26/2015	9:00:00 PM	0.66
7/26/2015	9:15:00 PM	0.66
7/26/2015	9:30:00 PM	0.66
7/26/2015	9:45:00 PM	0.66
7/26/2015	10:00:00 PM	0.66
7/26/2015	10:15:00 PM	0.66
7/26/2015	10:30:00 PM	0.66
7/26/2015	10:45:00 PM	0.66
7/26/2015	11:00:00 PM	0.66
7/26/2015	11:15:00 PM	0.66
7/26/2015	11:30:00 PM	0.66
7/26/2015	11:45:00 PM	0.66
7/27/2015	12:00:00 AM	0.66
7/27/2015	12:15:00 AM	0.67
7/27/2015	12:30:00 AM	0.66
7/27/2015	12:45:00 AM	0.66
7/27/2015	1:00:00 AM	0.66
7/27/2015	1:15:00 AM	0.66
7/27/2015	1:30:00 AM	0.66
7/27/2015	1:45:00 AM	0.66
7/27/2015	2:00:00 AM	0.66
7/27/2015	2:15:00 AM	0.66
7/27/2015	2:30:00 AM	0.65
7/27/2015	2:45:00 AM	0.66
7/27/2015	3:00:00 AM	0.67
7/27/2015	3:15:00 AM	0.66
7/27/2015	3:30:00 AM	0.66
7/27/2015	3:45:00 AM	0.66
7/27/2015	4:00:00 AM	0.66
7/27/2015	4:15:00 AM	0.66
7/27/2015	4:30:00 AM	0.66
7/27/2015	4:45:00 AM	0.66
7/27/2015	5:00:00 AM	0.67
7/27/2015	5:15:00 AM	0.66
7/27/2015	5:30:00 AM	0.66
7/27/2015	5:45:00 AM	0.66
7/27/2015	6:00:00 AM	0.66
7/27/2015	6:15:00 AM	0.66
7/27/2015	6:30:00 AM	0.65
7/27/2015	6:45:00 AM	0.66
7/27/2015	7:00:00 AM	0.66
7/27/2015	7:15:00 AM	0.66
7/27/2015	7:30:00 AM	0.66
7/27/2015	7:45:00 AM	0.66
7/27/2015	8:00:00 AM	0.65
7/27/2015	8:15:00 AM	0.66

Locust Ditch Return Gage

DATE	TIME	GAGE
7/27/2015	8:30:00 AM	0.66
7/27/2015	8:45:00 AM	0.66
7/27/2015	9:00:00 AM	0.66
7/27/2015	9:15:00 AM	0.65
7/27/2015	9:30:00 AM	0.66
7/27/2015	9:45:00 AM	0.66
7/27/2015	10:00:00 AM	0.66
7/27/2015	10:15:00 AM	0.66
7/27/2015	10:30:00 AM	0.66
7/27/2015	10:45:00 AM	0.66
7/27/2015	11:00:00 AM	0.66
7/27/2015	11:15:00 AM	0.66
7/27/2015	11:30:00 AM	0.65
7/27/2015	11:45:00 AM	0.66
7/27/2015	12:00:00 PM	0.66
7/27/2015	12:15:00 PM	0.66
7/27/2015	12:30:00 PM	0.66
7/27/2015	12:45:00 PM	0.66
7/27/2015	1:00:00 PM	0.66
7/27/2015	1:15:00 PM	0.66
7/27/2015	1:30:00 PM	0.65
7/27/2015	1:45:00 PM	0.66
7/27/2015	2:00:00 PM	0.66
7/27/2015	2:15:00 PM	0.66
7/27/2015	2:30:00 PM	0.66
7/27/2015	2:45:00 PM	0.65
7/27/2015	3:00:00 PM	0.65
7/27/2015	3:15:00 PM	0.66
7/27/2015	3:30:00 PM	0.66
7/27/2015	3:45:00 PM	0.66
7/27/2015	4:00:00 PM	0.65
7/27/2015	4:15:00 PM	0.66
7/27/2015	4:30:00 PM	0.65
7/27/2015	4:45:00 PM	0.66
7/27/2015	5:00:00 PM	0.65
7/27/2015	5:15:00 PM	0.65
7/27/2015	5:30:00 PM	0.66
7/27/2015	5:45:00 PM	0.66
7/27/2015	6:00:00 PM	0.66
7/27/2015	6:15:00 PM	0.66
7/27/2015	6:30:00 PM	0.66
7/27/2015	6:45:00 PM	0.66
7/27/2015	7:00:00 PM	0.66
7/27/2015	7:15:00 PM	0.66
7/27/2015	7:30:00 PM	0.66
7/27/2015	7:45:00 PM	0.66

Locust Ditch Return Gage

DATE	TIME	GAGE
7/27/2015	8:00:00 PM	0.66
7/27/2015	8:15:00 PM	0.66
7/27/2015	8:30:00 PM	0.66
7/27/2015	8:45:00 PM	0.66
7/27/2015	9:00:00 PM	0.66
7/27/2015	9:15:00 PM	0.66
7/27/2015	9:30:00 PM	0.66
7/27/2015	9:45:00 PM	0.66
7/27/2015	10:00:00 PM	0.65
7/27/2015	10:15:00 PM	0.66
7/27/2015	10:30:00 PM	0.66
7/27/2015	10:45:00 PM	0.66
7/27/2015	11:00:00 PM	0.66
7/27/2015	11:15:00 PM	0.65
7/27/2015	11:30:00 PM	0.66
7/27/2015	11:45:00 PM	0.65
7/28/2015	12:00:00 AM	0.66
7/28/2015	12:15:00 AM	0.66
7/28/2015	12:30:00 AM	0.66
7/28/2015	12:45:00 AM	0.66
7/28/2015	1:00:00 AM	0.66
7/28/2015	1:15:00 AM	0.66
7/28/2015	1:30:00 AM	0.66
7/28/2015	1:45:00 AM	0.66
7/28/2015	2:00:00 AM	0.66
7/28/2015	2:15:00 AM	0.66
7/28/2015	2:30:00 AM	0.65
7/28/2015	2:45:00 AM	0.66
7/28/2015	3:00:00 AM	0.66
7/28/2015	3:15:00 AM	0.66
7/28/2015	3:30:00 AM	0.66
7/28/2015	3:45:00 AM	0.66
7/28/2015	4:00:00 AM	0.66
7/28/2015	4:15:00 AM	0.66
7/28/2015	4:30:00 AM	0.66
7/28/2015	4:45:00 AM	0.66
7/28/2015	5:00:00 AM	0.66
7/28/2015	5:15:00 AM	0.66
7/28/2015	5:30:00 AM	0.66
7/28/2015	5:45:00 AM	0.66
7/28/2015	6:00:00 AM	0.66
7/28/2015	6:15:00 AM	0.66
7/28/2015	6:30:00 AM	0.66
7/28/2015	6:45:00 AM	0.66
7/28/2015	7:00:00 AM	0.66
7/28/2015	7:15:00 AM	0.65

Locust Ditch Return Gage

DATE	TIME	GAGE
7/28/2015	7:30:00 AM	0.66
7/28/2015	7:45:00 AM	0.65
7/28/2015	8:00:00 AM	0.66
7/28/2015	8:15:00 AM	0.66
7/28/2015	8:30:00 AM	0.65
7/28/2015	8:45:00 AM	0.66
7/28/2015	9:00:00 AM	0.66
7/28/2015	9:15:00 AM	0.66
7/28/2015	9:30:00 AM	0.65
7/28/2015	9:45:00 AM	0.65
7/28/2015	10:00:00 AM	0.66
7/28/2015	10:15:00 AM	0.66
7/28/2015	10:30:00 AM	0.66
7/28/2015	10:45:00 AM	0.66
7/28/2015	11:00:00 AM	0.66
7/28/2015	11:15:00 AM	0.66
7/28/2015	11:30:00 AM	0.66
7/28/2015	11:45:00 AM	0.66
7/28/2015	12:00:00 PM	0.66
7/28/2015	12:15:00 PM	0.66
7/28/2015	12:30:00 PM	0.66
7/28/2015	12:45:00 PM	0.66
7/28/2015	1:00:00 PM	0.66
7/28/2015	1:15:00 PM	0.66
7/28/2015	1:30:00 PM	0.66
7/28/2015	1:45:00 PM	0.66
7/28/2015	2:00:00 PM	0.65
7/28/2015	2:15:00 PM	0.65
7/28/2015	2:30:00 PM	0.66
7/28/2015	2:45:00 PM	0.66
7/28/2015	3:00:00 PM	0.66
7/28/2015	3:15:00 PM	0.66
7/28/2015	3:30:00 PM	0.66
7/28/2015	3:45:00 PM	0.66
7/28/2015	4:00:00 PM	0.66
7/28/2015	4:15:00 PM	0.66
7/28/2015	4:30:00 PM	0.66
7/28/2015	4:45:00 PM	0.67
7/28/2015	5:00:00 PM	0.66
7/28/2015	5:15:00 PM	0.66
7/28/2015	5:30:00 PM	0.66
7/28/2015	5:45:00 PM	0.66
7/28/2015	6:00:00 PM	0.66
7/28/2015	6:15:00 PM	0.66
7/28/2015	6:30:00 PM	0.66
7/28/2015	6:45:00 PM	0.67

Locust Ditch Return Gage

DATE	TIME	GAGE
7/28/2015	7:00:00 PM	0.66
7/28/2015	7:15:00 PM	0.67
7/28/2015	7:30:00 PM	0.67
7/28/2015	7:45:00 PM	0.66
7/28/2015	8:00:00 PM	0.67
7/28/2015	8:15:00 PM	0.66
7/28/2015	8:30:00 PM	0.66
7/28/2015	8:45:00 PM	0.66
7/28/2015	9:00:00 PM	0.66
7/28/2015	9:15:00 PM	0.67
7/28/2015	9:30:00 PM	0.66
7/28/2015	9:45:00 PM	0.66
7/28/2015	10:00:00 PM	0.66
7/28/2015	10:15:00 PM	0.66
7/28/2015	10:30:00 PM	0.66
7/28/2015	10:45:00 PM	0.66
7/28/2015	11:00:00 PM	0.66
7/28/2015	11:15:00 PM	0.66
7/28/2015	11:30:00 PM	0.66
7/28/2015	11:45:00 PM	0.66
7/29/2015	12:00:00 AM	0.67
7/29/2015	12:15:00 AM	0.66
7/29/2015	12:30:00 AM	0.67
7/29/2015	12:45:00 AM	0.66
7/29/2015	1:00:00 AM	0.67
7/29/2015	1:15:00 AM	0.67
7/29/2015	1:30:00 AM	0.67
7/29/2015	1:45:00 AM	0.66
7/29/2015	2:00:00 AM	0.67
7/29/2015	2:15:00 AM	0.67
7/29/2015	2:30:00 AM	0.67
7/29/2015	2:45:00 AM	0.66
7/29/2015	3:00:00 AM	0.67
7/29/2015	3:15:00 AM	0.67
7/29/2015	3:30:00 AM	0.66
7/29/2015	3:45:00 AM	0.67
7/29/2015	4:00:00 AM	0.66
7/29/2015	4:15:00 AM	0.66
7/29/2015	4:30:00 AM	0.66
7/29/2015	4:45:00 AM	0.66
7/29/2015	5:00:00 AM	0.67
7/29/2015	5:15:00 AM	0.67
7/29/2015	5:30:00 AM	0.67
7/29/2015	5:45:00 AM	0.67
7/29/2015	6:00:00 AM	0.67
7/29/2015	6:15:00 AM	0.67

Locust Ditch Return Gage

DATE	TIME	GAGE
7/29/2015	6:30:00 AM	0.67
7/29/2015	6:45:00 AM	0.66
7/29/2015	7:00:00 AM	0.67
7/29/2015	7:15:00 AM	0.67
7/29/2015	7:30:00 AM	0.66
7/29/2015	7:45:00 AM	0.67
7/29/2015	8:00:00 AM	0.67
7/29/2015	8:15:00 AM	0.67
7/29/2015	8:30:00 AM	0.67
7/29/2015	8:45:00 AM	0.67
7/29/2015	9:00:00 AM	0.66
7/29/2015	9:15:00 AM	0.66
7/29/2015	9:30:00 AM	0.66
7/29/2015	9:45:00 AM	0.66
7/29/2015	10:00:00 AM	0.67
7/29/2015	10:15:00 AM	0.66
7/29/2015	10:30:00 AM	0.66
7/29/2015	10:45:00 AM	0.67
7/29/2015	11:00:00 AM	0.66
7/29/2015	11:15:00 AM	0.66
7/29/2015	11:30:00 AM	0.66
7/29/2015	11:45:00 AM	0.66
7/29/2015	12:00:00 PM	0.66
7/29/2015	12:15:00 PM	0.67
7/29/2015	12:30:00 PM	0.66
7/29/2015	12:45:00 PM	0.67
7/29/2015	1:00:00 PM	0.67
7/29/2015	1:15:00 PM	0.66
7/29/2015	1:30:00 PM	0.67
7/29/2015	1:45:00 PM	0.66
7/29/2015	2:00:00 PM	0.66
7/29/2015	2:15:00 PM	0.66
7/29/2015	2:30:00 PM	0.66
7/29/2015	2:45:00 PM	0.67
7/29/2015	3:00:00 PM	0.67
7/29/2015	3:15:00 PM	0.67
7/29/2015	3:30:00 PM	0.67
7/29/2015	3:45:00 PM	0.67
7/29/2015	4:00:00 PM	0.66
7/29/2015	4:15:00 PM	0.67
7/29/2015	4:30:00 PM	0.66
7/29/2015	4:45:00 PM	0.67
7/29/2015	5:00:00 PM	0.67
7/29/2015	5:15:00 PM	0.67
7/29/2015	5:30:00 PM	0.66
7/29/2015	5:45:00 PM	0.67

Locust Ditch Return Gage

DATE	TIME	GAGE
7/29/2015	6:00:00 PM	0.67
7/29/2015	6:15:00 PM	0.67
7/29/2015	6:30:00 PM	0.67
7/29/2015	6:45:00 PM	0.67
7/29/2015	7:00:00 PM	0.67
7/29/2015	7:15:00 PM	0.67
7/29/2015	7:30:00 PM	0.67
7/29/2015	7:45:00 PM	0.67
7/29/2015	8:00:00 PM	0.66
7/29/2015	8:15:00 PM	0.67
7/29/2015	8:30:00 PM	0.67
7/29/2015	8:45:00 PM	0.67
7/29/2015	9:00:00 PM	0.67
7/29/2015	9:15:00 PM	0.67
7/29/2015	9:30:00 PM	0.67
7/29/2015	9:45:00 PM	0.67
7/29/2015	10:00:00 PM	0.67
7/29/2015	10:15:00 PM	0.67
7/29/2015	10:30:00 PM	0.67
7/29/2015	10:45:00 PM	0.67
7/29/2015	11:00:00 PM	0.67
7/29/2015	11:15:00 PM	0.67
7/29/2015	11:30:00 PM	0.67
7/29/2015	11:45:00 PM	0.67
7/30/2015	12:00:00 AM	0.67
7/30/2015	12:15:00 AM	0.67
7/30/2015	12:30:00 AM	0.67
7/30/2015	12:45:00 AM	0.67
7/30/2015	1:00:00 AM	0.67
7/30/2015	1:15:00 AM	0.67
7/30/2015	1:30:00 AM	0.67
7/30/2015	1:45:00 AM	0.67
7/30/2015	2:00:00 AM	0.67
7/30/2015	2:15:00 AM	0.67
7/30/2015	2:30:00 AM	0.67
7/30/2015	2:45:00 AM	0.67
7/30/2015	3:00:00 AM	0.67
7/30/2015	3:15:00 AM	0.66
7/30/2015	3:30:00 AM	0.67
7/30/2015	3:45:00 AM	0.67
7/30/2015	4:00:00 AM	0.67
7/30/2015	4:15:00 AM	0.67
7/30/2015	4:30:00 AM	0.67
7/30/2015	4:45:00 AM	0.67
7/30/2015	5:00:00 AM	0.67
7/30/2015	5:15:00 AM	0.67

Locust Ditch Return Gage

DATE	TIME	GAGE
7/30/2015	5:30:00 AM	0.67
7/30/2015	5:45:00 AM	0.67
7/30/2015	6:00:00 AM	0.67
7/30/2015	6:15:00 AM	0.67
7/30/2015	6:30:00 AM	0.67
7/30/2015	6:45:00 AM	0.66
7/30/2015	7:00:00 AM	0.67
7/30/2015	7:15:00 AM	0.66
7/30/2015	7:30:00 AM	0.67
7/30/2015	7:45:00 AM	0.67
7/30/2015	8:00:00 AM	0.67
7/30/2015	8:15:00 AM	0.67
7/30/2015	8:30:00 AM	0.67
7/30/2015	8:45:00 AM	0.67
7/30/2015	9:00:00 AM	0.67
7/30/2015	9:15:00 AM	0.67
7/30/2015	9:30:00 AM	0.66
7/30/2015	9:45:00 AM	0.67
7/30/2015	10:00:00 AM	0.67
7/30/2015	10:15:00 AM	0.66
7/30/2015	10:30:00 AM	0.67
7/30/2015	10:45:00 AM	0.67
7/30/2015	11:00:00 AM	0.67
7/30/2015	11:15:00 AM	0.67
7/30/2015	11:30:00 AM	0.67
7/30/2015	11:45:00 AM	0.67
7/30/2015	12:00:00 PM	0.67
7/30/2015	12:15:00 PM	0.67
7/30/2015	12:30:00 PM	0.67
7/30/2015	12:45:00 PM	0.67
7/30/2015	1:00:00 PM	0.68
7/30/2015	1:15:00 PM	0.67
7/30/2015	1:30:00 PM	0.68
7/30/2015	1:45:00 PM	0.68
7/30/2015	2:00:00 PM	0.68
7/30/2015	2:15:00 PM	0.68
7/30/2015	2:30:00 PM	0.68
7/30/2015	2:45:00 PM	0.67
7/30/2015	3:00:00 PM	0.68
7/30/2015	3:15:00 PM	0.68
7/30/2015	3:30:00 PM	0.68
7/30/2015	3:45:00 PM	0.68
7/30/2015	4:00:00 PM	0.68
7/30/2015	4:15:00 PM	0.68
7/30/2015	4:30:00 PM	0.68
7/30/2015	4:45:00 PM	0.68

Locust Ditch Return Gage

DATE	TIME	GAGE
7/30/2015	5:00:00 PM	0.68
7/30/2015	5:15:00 PM	0.68
7/30/2015	5:30:00 PM	0.68
7/30/2015	5:45:00 PM	0.68
7/30/2015	6:00:00 PM	0.67
7/30/2015	6:15:00 PM	0.67
7/30/2015	6:30:00 PM	0.68
7/30/2015	6:45:00 PM	0.68
7/30/2015	7:00:00 PM	0.68
7/30/2015	7:15:00 PM	0.68
7/30/2015	7:30:00 PM	0.68
7/30/2015	7:45:00 PM	0.67
7/30/2015	8:00:00 PM	0.68
7/30/2015	8:15:00 PM	0.68
7/30/2015	8:30:00 PM	0.68
7/30/2015	8:45:00 PM	0.68
7/30/2015	9:00:00 PM	0.68
7/30/2015	9:15:00 PM	0.68
7/30/2015	9:30:00 PM	0.68
7/30/2015	9:45:00 PM	0.67
7/30/2015	10:00:00 PM	0.68
7/30/2015	10:15:00 PM	0.68
7/30/2015	10:30:00 PM	0.68
7/30/2015	10:45:00 PM	0.68
7/30/2015	11:00:00 PM	0.68
7/30/2015	11:15:00 PM	0.68
7/30/2015	11:30:00 PM	0.67
7/30/2015	11:45:00 PM	0.68
7/31/2015	12:00:00 AM	0.68
7/31/2015	12:15:00 AM	0.68
7/31/2015	12:30:00 AM	0.68
7/31/2015	12:45:00 AM	0.68
7/31/2015	1:00:00 AM	0.68
7/31/2015	1:15:00 AM	0.68
7/31/2015	1:30:00 AM	0.68
7/31/2015	1:45:00 AM	0.68
7/31/2015	2:00:00 AM	0.68
7/31/2015	2:15:00 AM	0.68
7/31/2015	2:30:00 AM	0.68
7/31/2015	2:45:00 AM	0.68
7/31/2015	3:00:00 AM	0.68
7/31/2015	3:15:00 AM	0.68
7/31/2015	3:30:00 AM	0.68
7/31/2015	3:45:00 AM	0.68
7/31/2015	4:00:00 AM	0.68
7/31/2015	4:15:00 AM	0.68

Locust Ditch Return Gage

DATE	TIME	GAGE
7/31/2015	4:30:00 AM	0.68
7/31/2015	4:45:00 AM	0.68
7/31/2015	5:00:00 AM	0.68
7/31/2015	5:15:00 AM	0.68
7/31/2015	5:30:00 AM	0.69
7/31/2015	5:45:00 AM	0.68
7/31/2015	6:00:00 AM	0.68
7/31/2015	6:15:00 AM	0.68
7/31/2015	6:30:00 AM	0.68
7/31/2015	6:45:00 AM	0.68
7/31/2015	7:00:00 AM	0.68
7/31/2015	7:15:00 AM	0.68
7/31/2015	7:30:00 AM	0.68
7/31/2015	7:45:00 AM	0.68
7/31/2015	8:00:00 AM	0.68
7/31/2015	8:15:00 AM	0.68
7/31/2015	8:30:00 AM	0.68
7/31/2015	8:45:00 AM	0.68
7/31/2015	9:00:00 AM	0.68
7/31/2015	9:15:00 AM	0.68
7/31/2015	9:30:00 AM	0.68
7/31/2015	9:45:00 AM	0.68
7/31/2015	10:00:00 AM	0.68
7/31/2015	10:15:00 AM	0.67
7/31/2015	10:30:00 AM	0.69
7/31/2015	10:45:00 AM	0.68
7/31/2015	11:00:00 AM	0.68
7/31/2015	11:15:00 AM	0.67
7/31/2015	11:30:00 AM	0.69
7/31/2015	11:45:00 AM	0.68
7/31/2015	12:00:00 PM	0.68
7/31/2015	12:15:00 PM	0.68
7/31/2015	12:30:00 PM	0.68
7/31/2015	12:45:00 PM	0.68
7/31/2015	1:00:00 PM	0.69
7/31/2015	1:15:00 PM	0.68
7/31/2015	1:30:00 PM	0.69
7/31/2015	1:45:00 PM	0.67
7/31/2015	2:00:00 PM	0.68
7/31/2015	2:15:00 PM	0.68
7/31/2015	2:30:00 PM	0.68
7/31/2015	2:45:00 PM	0.68
7/31/2015	3:00:00 PM	0.68
7/31/2015	3:15:00 PM	0.68
7/31/2015	3:30:00 PM	0.68
7/31/2015	3:45:00 PM	0.68

Locust Ditch Return Gage

DATE	TIME	GAGE
7/31/2015	4:00:00 PM	0.68
7/31/2015	4:15:00 PM	0.68
7/31/2015	4:30:00 PM	0.69
7/31/2015	4:45:00 PM	0.68
7/31/2015	5:00:00 PM	0.67
7/31/2015	5:15:00 PM	0.68
7/31/2015	5:30:00 PM	0.68
7/31/2015	5:45:00 PM	0.68
7/31/2015	6:00:00 PM	0.68
7/31/2015	6:15:00 PM	0.68
7/31/2015	6:30:00 PM	0.68
7/31/2015	6:45:00 PM	0.68
7/31/2015	7:00:00 PM	0.68
7/31/2015	7:15:00 PM	0.68
7/31/2015	7:30:00 PM	0.68
7/31/2015	7:45:00 PM	0.68
7/31/2015	8:00:00 PM	0.68
7/31/2015	8:15:00 PM	0.68
7/31/2015	8:30:00 PM	0.68
7/31/2015	8:45:00 PM	0.68
7/31/2015	9:00:00 PM	0.68
7/31/2015	9:15:00 PM	0.67
7/31/2015	9:30:00 PM	0.68
7/31/2015	9:45:00 PM	0.68
7/31/2015	10:00:00 PM	0.68
7/31/2015	10:15:00 PM	0.69
7/31/2015	10:30:00 PM	0.68
7/31/2015	10:45:00 PM	0.68
7/31/2015	11:00:00 PM	0.68
7/31/2015	11:15:00 PM	0.69
7/31/2015	11:30:00 PM	0.68
7/31/2015	11:45:00 PM	0.69

Georges Ditch Return

Station 0217

Date	Flow (cfs)
7/1/2015	3.673
7/2/2015	8.881
7/3/2015	8.881
7/4/2015	8.442
7/5/2015	8.724
7/6/2015	10.416
7/7/2015	10.285
7/8/2015	8.46
7/9/2015	4.238
7/10/2015	4.905
7/11/2015	5.301
7/12/2015	4.862
7/13/2015	6.832
7/14/2015	10.289
7/15/2015	9.819
7/16/2015	9.525
7/17/2015	8.755
7/18/2015	7.153
7/19/2015	6.893
7/20/2015	8.731
7/21/2015	5.542
7/22/2015	1.274
7/23/2015	0.084
7/24/2015	3.179
7/25/2015	4.702
7/26/2015	3.528
7/27/2015	3.454
7/28/2015	1.966
7/29/2015	0.194
7/30/2015	0
7/31/2015	0.044

Georges Ditch Return Gage

DATE	TIME	GAGE
7/1/2015	12:00:00 AM	0.17
7/1/2015	12:15:00 AM	0.17
7/1/2015	12:30:00 AM	0.17
7/1/2015	12:45:00 AM	0.16
7/1/2015	1:00:00 AM	0.16
7/1/2015	1:15:00 AM	0.16
7/1/2015	1:30:00 AM	0.15
7/1/2015	1:45:00 AM	0.15
7/1/2015	2:00:00 AM	0.15
7/1/2015	2:15:00 AM	0.15
7/1/2015	2:30:00 AM	0.15
7/1/2015	2:45:00 AM	0.15
7/1/2015	3:00:00 AM	0.15
7/1/2015	3:15:00 AM	0.15
7/1/2015	3:30:00 AM	0.15
7/1/2015	3:45:00 AM	0.16
7/1/2015	4:00:00 AM	0.16
7/1/2015	4:15:00 AM	0.16
7/1/2015	4:30:00 AM	0.16
7/1/2015	4:45:00 AM	0.16
7/1/2015	5:00:00 AM	0.16
7/1/2015	5:15:00 AM	0.16
7/1/2015	5:30:00 AM	0.16
7/1/2015	5:45:00 AM	0.16
7/1/2015	6:00:00 AM	0.15
7/1/2015	6:15:00 AM	0.16
7/1/2015	6:30:00 AM	0.15
7/1/2015	6:45:00 AM	0.15
7/1/2015	7:00:00 AM	0.15
7/1/2015	7:15:00 AM	0.16
7/1/2015	7:30:00 AM	0.16
7/1/2015	7:45:00 AM	0.16
7/1/2015	8:00:00 AM	0.16
7/1/2015	8:15:00 AM	0.16
7/1/2015	8:30:00 AM	0.16
7/1/2015	8:45:00 AM	0.15
7/1/2015	9:00:00 AM	0.15
7/1/2015	9:15:00 AM	0.15
7/1/2015	9:30:00 AM	0.15
7/1/2015	9:45:00 AM	0.15
7/1/2015	10:00:00 AM	0.15
7/1/2015	10:15:00 AM	0.15
7/1/2015	10:30:00 AM	0.15
7/1/2015	10:45:00 AM	0.15
7/1/2015	11:00:00 AM	0.14
7/1/2015	11:15:00 AM	0.14

Georges Ditch Return Gage

DATE	TIME	GAGE
7/1/2015	11:30:00 AM	0.14
7/1/2015	11:45:00 AM	0.14
7/1/2015	12:00:00 PM	0.14
7/1/2015	12:15:00 PM	0.14
7/1/2015	12:30:00 PM	0.14
7/1/2015	12:45:00 PM	0.14
7/1/2015	1:00:00 PM	0.14
7/1/2015	1:15:00 PM	0.14
7/1/2015	1:30:00 PM	0.14
7/1/2015	1:45:00 PM	0.14
7/1/2015	2:00:00 PM	0.14
7/1/2015	2:15:00 PM	0.14
7/1/2015	2:30:00 PM	0.45
7/1/2015	2:45:00 PM	0.45
7/1/2015	3:00:00 PM	0.45
7/1/2015	3:15:00 PM	0.46
7/1/2015	3:30:00 PM	0.46
7/1/2015	3:45:00 PM	0.46
7/1/2015	4:00:00 PM	0.46
7/1/2015	4:15:00 PM	0.46
7/1/2015	4:30:00 PM	0.46
7/1/2015	4:45:00 PM	0.46
7/1/2015	5:00:00 PM	0.51
7/1/2015	5:15:00 PM	0.59
7/1/2015	5:30:00 PM	0.63
7/1/2015	5:45:00 PM	0.64
7/1/2015	6:00:00 PM	0.64
7/1/2015	6:15:00 PM	0.64
7/1/2015	6:30:00 PM	0.65
7/1/2015	6:45:00 PM	0.64
7/1/2015	7:00:00 PM	0.64
7/1/2015	7:15:00 PM	0.64
7/1/2015	7:30:00 PM	0.64
7/1/2015	7:45:00 PM	0.64
7/1/2015	8:00:00 PM	0.64
7/1/2015	8:15:00 PM	0.64
7/1/2015	8:30:00 PM	0.64
7/1/2015	8:45:00 PM	0.64
7/1/2015	9:00:00 PM	0.64
7/1/2015	9:15:00 PM	0.64
7/1/2015	9:30:00 PM	0.64
7/1/2015	9:45:00 PM	0.64
7/1/2015	10:00:00 PM	0.64
7/1/2015	10:15:00 PM	0.64
7/1/2015	10:30:00 PM	0.64
7/1/2015	10:45:00 PM	0.65

Georges Ditch Return Gage

DATE	TIME	GAGE
7/1/2015	11:00:00 PM	0.65
7/1/2015	11:15:00 PM	0.65
7/1/2015	11:30:00 PM	0.65
7/1/2015	11:45:00 PM	0.65
7/2/2015	12:00:00 AM	0.65
7/2/2015	12:15:00 AM	0.65
7/2/2015	12:30:00 AM	0.65
7/2/2015	12:45:00 AM	0.65
7/2/2015	1:00:00 AM	0.65
7/2/2015	1:15:00 AM	0.65
7/2/2015	1:30:00 AM	0.65
7/2/2015	1:45:00 AM	0.65
7/2/2015	2:00:00 AM	0.65
7/2/2015	2:15:00 AM	0.65
7/2/2015	2:30:00 AM	0.65
7/2/2015	2:45:00 AM	0.65
7/2/2015	3:00:00 AM	0.65
7/2/2015	3:15:00 AM	0.65
7/2/2015	3:30:00 AM	0.65
7/2/2015	3:45:00 AM	0.65
7/2/2015	4:00:00 AM	0.65
7/2/2015	4:15:00 AM	0.65
7/2/2015	4:30:00 AM	0.65
7/2/2015	4:45:00 AM	0.65
7/2/2015	5:00:00 AM	0.65
7/2/2015	5:15:00 AM	0.65
7/2/2015	5:30:00 AM	0.65
7/2/2015	5:45:00 AM	0.65
7/2/2015	6:00:00 AM	0.65
7/2/2015	6:15:00 AM	0.65
7/2/2015	6:30:00 AM	0.65
7/2/2015	6:45:00 AM	0.65
7/2/2015	7:00:00 AM	0.65
7/2/2015	7:15:00 AM	0.65
7/2/2015	7:30:00 AM	0.65
7/2/2015	7:45:00 AM	0.65
7/2/2015	8:00:00 AM	0.65
7/2/2015	8:15:00 AM	0.65
7/2/2015	8:30:00 AM	0.65
7/2/2015	8:45:00 AM	0.66
7/2/2015	9:00:00 AM	0.66
7/2/2015	9:15:00 AM	0.66
7/2/2015	9:30:00 AM	0.66
7/2/2015	9:45:00 AM	0.66
7/2/2015	10:00:00 AM	0.66
7/2/2015	10:15:00 AM	0.66

Georges Ditch Return Gage

DATE	TIME	GAGE
7/2/2015	10:30:00 AM	0.66
7/2/2015	10:45:00 AM	0.66
7/2/2015	11:00:00 AM	0.66
7/2/2015	11:15:00 AM	0.66
7/2/2015	11:30:00 AM	0.66
7/2/2015	11:45:00 AM	0.66
7/2/2015	12:00:00 PM	0.66
7/2/2015	12:15:00 PM	0.66
7/2/2015	12:30:00 PM	0.66
7/2/2015	12:45:00 PM	0.66
7/2/2015	1:00:00 PM	0.66
7/2/2015	1:15:00 PM	0.66
7/2/2015	1:30:00 PM	0.66
7/2/2015	1:45:00 PM	0.66
7/2/2015	2:00:00 PM	0.65
7/2/2015	2:15:00 PM	0.65
7/2/2015	2:30:00 PM	0.65
7/2/2015	2:45:00 PM	0.65
7/2/2015	3:00:00 PM	0.65
7/2/2015	3:15:00 PM	0.65
7/2/2015	3:30:00 PM	0.65
7/2/2015	3:45:00 PM	0.65
7/2/2015	4:00:00 PM	0.65
7/2/2015	4:15:00 PM	0.65
7/2/2015	4:30:00 PM	0.65
7/2/2015	4:45:00 PM	0.65
7/2/2015	5:00:00 PM	0.65
7/2/2015	5:15:00 PM	0.65
7/2/2015	5:30:00 PM	0.65
7/2/2015	5:45:00 PM	0.65
7/2/2015	6:00:00 PM	0.65
7/2/2015	6:15:00 PM	0.65
7/2/2015	6:30:00 PM	0.65
7/2/2015	6:45:00 PM	0.65
7/2/2015	7:00:00 PM	0.65
7/2/2015	7:15:00 PM	0.65
7/2/2015	7:30:00 PM	0.65
7/2/2015	7:45:00 PM	0.65
7/2/2015	8:00:00 PM	0.65
7/2/2015	8:15:00 PM	0.65
7/2/2015	8:30:00 PM	0.65
7/2/2015	8:45:00 PM	0.65
7/2/2015	9:00:00 PM	0.65
7/2/2015	9:15:00 PM	0.65
7/2/2015	9:30:00 PM	0.65
7/2/2015	9:45:00 PM	0.65

Georges Ditch Return Gage

DATE	TIME	GAGE
7/2/2015	10:00:00 PM	0.65
7/2/2015	10:15:00 PM	0.65
7/2/2015	10:30:00 PM	0.66
7/2/2015	10:45:00 PM	0.66
7/2/2015	11:00:00 PM	0.66
7/2/2015	11:15:00 PM	0.66
7/2/2015	11:30:00 PM	0.66
7/2/2015	11:45:00 PM	0.66
7/3/2015	12:00:00 AM	0.66
7/3/2015	12:15:00 AM	0.66
7/3/2015	12:30:00 AM	0.66
7/3/2015	12:45:00 AM	0.66
7/3/2015	1:00:00 AM	0.66
7/3/2015	1:15:00 AM	0.66
7/3/2015	1:30:00 AM	0.66
7/3/2015	1:45:00 AM	0.66
7/3/2015	2:00:00 AM	0.66
7/3/2015	2:15:00 AM	0.66
7/3/2015	2:30:00 AM	0.66
7/3/2015	2:45:00 AM	0.66
7/3/2015	3:00:00 AM	0.66
7/3/2015	3:15:00 AM	0.66
7/3/2015	3:30:00 AM	0.66
7/3/2015	3:45:00 AM	0.66
7/3/2015	4:00:00 AM	0.66
7/3/2015	4:15:00 AM	0.66
7/3/2015	4:30:00 AM	0.66
7/3/2015	4:45:00 AM	0.66
7/3/2015	5:00:00 AM	0.66
7/3/2015	5:15:00 AM	0.66
7/3/2015	5:30:00 AM	0.66
7/3/2015	5:45:00 AM	0.66
7/3/2015	6:00:00 AM	0.66
7/3/2015	6:15:00 AM	0.66
7/3/2015	6:30:00 AM	0.66
7/3/2015	6:45:00 AM	0.66
7/3/2015	7:00:00 AM	0.66
7/3/2015	7:15:00 AM	0.66
7/3/2015	7:30:00 AM	0.66
7/3/2015	7:45:00 AM	0.66
7/3/2015	8:00:00 AM	0.66
7/3/2015	8:15:00 AM	0.66
7/3/2015	8:30:00 AM	0.66
7/3/2015	8:45:00 AM	0.66
7/3/2015	9:00:00 AM	0.66
7/3/2015	9:15:00 AM	0.66

Georges Ditch Return Gage

DATE	TIME	GAGE
7/3/2015	9:30:00 AM	0.66
7/3/2015	9:45:00 AM	0.66
7/3/2015	10:00:00 AM	0.66
7/3/2015	10:15:00 AM	0.66
7/3/2015	10:30:00 AM	0.66
7/3/2015	10:45:00 AM	0.66
7/3/2015	11:00:00 AM	0.66
7/3/2015	11:15:00 AM	0.66
7/3/2015	11:30:00 AM	0.66
7/3/2015	11:45:00 AM	0.66
7/3/2015	12:00:00 PM	0.65
7/3/2015	12:15:00 PM	0.65
7/3/2015	12:30:00 PM	0.65
7/3/2015	12:45:00 PM	0.65
7/3/2015	1:00:00 PM	0.65
7/3/2015	1:15:00 PM	0.65
7/3/2015	1:30:00 PM	0.65
7/3/2015	1:45:00 PM	0.65
7/3/2015	2:00:00 PM	0.65
7/3/2015	2:15:00 PM	0.65
7/3/2015	2:30:00 PM	0.65
7/3/2015	2:45:00 PM	0.65
7/3/2015	3:00:00 PM	0.65
7/3/2015	3:15:00 PM	0.65
7/3/2015	3:30:00 PM	0.65
7/3/2015	3:45:00 PM	0.65
7/3/2015	4:00:00 PM	0.65
7/3/2015	4:15:00 PM	0.65
7/3/2015	4:30:00 PM	0.65
7/3/2015	4:45:00 PM	0.64
7/3/2015	5:00:00 PM	0.64
7/3/2015	5:15:00 PM	0.64
7/3/2015	5:30:00 PM	0.64
7/3/2015	5:45:00 PM	0.64
7/3/2015	6:00:00 PM	0.64
7/3/2015	6:15:00 PM	0.64
7/3/2015	6:30:00 PM	0.64
7/3/2015	6:45:00 PM	0.64
7/3/2015	7:00:00 PM	0.64
7/3/2015	7:15:00 PM	0.64
7/3/2015	7:30:00 PM	0.64
7/3/2015	7:45:00 PM	0.64
7/3/2015	8:00:00 PM	0.64
7/3/2015	8:15:00 PM	0.64
7/3/2015	8:30:00 PM	0.64
7/3/2015	8:45:00 PM	0.64

Georges Ditch Return Gage

DATE	TIME	GAGE
7/3/2015	9:00:00 PM	0.64
7/3/2015	9:15:00 PM	0.64
7/3/2015	9:30:00 PM	0.64
7/3/2015	9:45:00 PM	0.65
7/3/2015	10:00:00 PM	0.65
7/3/2015	10:15:00 PM	0.65
7/3/2015	10:30:00 PM	0.65
7/3/2015	10:45:00 PM	0.65
7/3/2015	11:00:00 PM	0.65
7/3/2015	11:15:00 PM	0.65
7/3/2015	11:30:00 PM	0.65
7/3/2015	11:45:00 PM	0.65
7/4/2015	12:00:00 AM	0.65
7/4/2015	12:15:00 AM	0.65
7/4/2015	12:30:00 AM	0.65
7/4/2015	12:45:00 AM	0.64
7/4/2015	1:00:00 AM	0.64
7/4/2015	1:15:00 AM	0.64
7/4/2015	1:30:00 AM	0.64
7/4/2015	1:45:00 AM	0.64
7/4/2015	2:00:00 AM	0.64
7/4/2015	2:15:00 AM	0.64
7/4/2015	2:30:00 AM	0.64
7/4/2015	2:45:00 AM	0.64
7/4/2015	3:00:00 AM	0.64
7/4/2015	3:15:00 AM	0.64
7/4/2015	3:30:00 AM	0.64
7/4/2015	3:45:00 AM	0.64
7/4/2015	4:00:00 AM	0.64
7/4/2015	4:15:00 AM	0.64
7/4/2015	4:30:00 AM	0.64
7/4/2015	4:45:00 AM	0.64
7/4/2015	5:00:00 AM	0.64
7/4/2015	5:15:00 AM	0.64
7/4/2015	5:30:00 AM	0.64
7/4/2015	5:45:00 AM	0.64
7/4/2015	6:00:00 AM	0.64
7/4/2015	6:15:00 AM	0.64
7/4/2015	6:30:00 AM	0.64
7/4/2015	6:45:00 AM	0.64
7/4/2015	7:00:00 AM	0.64
7/4/2015	7:15:00 AM	0.64
7/4/2015	7:30:00 AM	0.64
7/4/2015	7:45:00 AM	0.64
7/4/2015	8:00:00 AM	0.64
7/4/2015	8:15:00 AM	0.64

Georges Ditch Return Gage

DATE	TIME	GAGE
7/4/2015	8:30:00 AM	0.64
7/4/2015	8:45:00 AM	0.64
7/4/2015	9:00:00 AM	0.64
7/4/2015	9:15:00 AM	0.64
7/4/2015	9:30:00 AM	0.64
7/4/2015	9:45:00 AM	0.64
7/4/2015	10:00:00 AM	0.64
7/4/2015	10:15:00 AM	0.64
7/4/2015	10:30:00 AM	0.64
7/4/2015	10:45:00 AM	0.64
7/4/2015	11:00:00 AM	0.64
7/4/2015	11:15:00 AM	0.64
7/4/2015	11:30:00 AM	0.64
7/4/2015	11:45:00 AM	0.64
7/4/2015	12:00:00 PM	0.64
7/4/2015	12:15:00 PM	0.63
7/4/2015	12:30:00 PM	0.63
7/4/2015	12:45:00 PM	0.63
7/4/2015	1:00:00 PM	0.63
7/4/2015	1:15:00 PM	0.63
7/4/2015	1:30:00 PM	0.63
7/4/2015	1:45:00 PM	0.62
7/4/2015	2:00:00 PM	0.62
7/4/2015	2:15:00 PM	0.62
7/4/2015	2:30:00 PM	0.62
7/4/2015	2:45:00 PM	0.62
7/4/2015	3:00:00 PM	0.62
7/4/2015	3:15:00 PM	0.62
7/4/2015	3:30:00 PM	0.62
7/4/2015	3:45:00 PM	0.62
7/4/2015	4:00:00 PM	0.62
7/4/2015	4:15:00 PM	0.62
7/4/2015	4:30:00 PM	0.62
7/4/2015	4:45:00 PM	0.62
7/4/2015	5:00:00 PM	0.62
7/4/2015	5:15:00 PM	0.62
7/4/2015	5:30:00 PM	0.62
7/4/2015	5:45:00 PM	0.62
7/4/2015	6:00:00 PM	0.62
7/4/2015	6:15:00 PM	0.62
7/4/2015	6:30:00 PM	0.62
7/4/2015	6:45:00 PM	0.62
7/4/2015	7:00:00 PM	0.62
7/4/2015	7:15:00 PM	0.62
7/4/2015	7:30:00 PM	0.62
7/4/2015	7:45:00 PM	0.62

Georges Ditch Return Gage

DATE	TIME	GAGE
7/4/2015	8:00:00 PM	0.62
7/4/2015	8:15:00 PM	0.62
7/4/2015	8:30:00 PM	0.62
7/4/2015	8:45:00 PM	0.62
7/4/2015	9:00:00 PM	0.62
7/4/2015	9:15:00 PM	0.62
7/4/2015	9:30:00 PM	0.62
7/4/2015	9:45:00 PM	0.62
7/4/2015	10:00:00 PM	0.62
7/4/2015	10:15:00 PM	0.62
7/4/2015	10:30:00 PM	0.62
7/4/2015	10:45:00 PM	0.62
7/4/2015	11:00:00 PM	0.62
7/4/2015	11:15:00 PM	0.62
7/4/2015	11:30:00 PM	0.62
7/4/2015	11:45:00 PM	0.63
7/5/2015	12:00:00 AM	0.63
7/5/2015	12:15:00 AM	0.63
7/5/2015	12:30:00 AM	0.62
7/5/2015	12:45:00 AM	0.62
7/5/2015	1:00:00 AM	0.62
7/5/2015	1:15:00 AM	0.62
7/5/2015	1:30:00 AM	0.62
7/5/2015	1:45:00 AM	0.62
7/5/2015	2:00:00 AM	0.62
7/5/2015	2:15:00 AM	0.62
7/5/2015	2:30:00 AM	0.62
7/5/2015	2:45:00 AM	0.62
7/5/2015	3:00:00 AM	0.63
7/5/2015	3:15:00 AM	0.63
7/5/2015	3:30:00 AM	0.63
7/5/2015	3:45:00 AM	0.63
7/5/2015	4:00:00 AM	0.63
7/5/2015	4:15:00 AM	0.63
7/5/2015	4:30:00 AM	0.63
7/5/2015	4:45:00 AM	0.63
7/5/2015	5:00:00 AM	0.63
7/5/2015	5:15:00 AM	0.63
7/5/2015	5:30:00 AM	0.63
7/5/2015	5:45:00 AM	0.63
7/5/2015	6:00:00 AM	0.63
7/5/2015	6:15:00 AM	0.63
7/5/2015	6:30:00 AM	0.63
7/5/2015	6:45:00 AM	0.63
7/5/2015	7:00:00 AM	0.63
7/5/2015	7:15:00 AM	0.63

Georges Ditch Return Gage

DATE	TIME	GAGE
7/5/2015	7:30:00 AM	0.63
7/5/2015	7:45:00 AM	0.63
7/5/2015	8:00:00 AM	0.63
7/5/2015	8:15:00 AM	0.63
7/5/2015	8:30:00 AM	0.63
7/5/2015	8:45:00 AM	0.63
7/5/2015	9:00:00 AM	0.63
7/5/2015	9:15:00 AM	0.63
7/5/2015	9:30:00 AM	0.63
7/5/2015	9:45:00 AM	0.63
7/5/2015	10:00:00 AM	0.63
7/5/2015	10:15:00 AM	0.63
7/5/2015	10:30:00 AM	0.63
7/5/2015	10:45:00 AM	0.63
7/5/2015	11:00:00 AM	0.63
7/5/2015	11:15:00 AM	0.63
7/5/2015	11:30:00 AM	0.63
7/5/2015	11:45:00 AM	0.63
7/5/2015	12:00:00 PM	0.63
7/5/2015	12:15:00 PM	0.63
7/5/2015	12:30:00 PM	0.63
7/5/2015	12:45:00 PM	0.62
7/5/2015	1:00:00 PM	0.62
7/5/2015	1:15:00 PM	0.62
7/5/2015	1:30:00 PM	0.62
7/5/2015	1:45:00 PM	0.62
7/5/2015	2:00:00 PM	0.62
7/5/2015	2:15:00 PM	0.62
7/5/2015	2:30:00 PM	0.62
7/5/2015	2:45:00 PM	0.62
7/5/2015	3:00:00 PM	0.62
7/5/2015	3:15:00 PM	0.62
7/5/2015	3:30:00 PM	0.62
7/5/2015	3:45:00 PM	0.62
7/5/2015	4:00:00 PM	0.62
7/5/2015	4:15:00 PM	0.62
7/5/2015	4:30:00 PM	0.62
7/5/2015	4:45:00 PM	0.62
7/5/2015	5:00:00 PM	0.62
7/5/2015	5:15:00 PM	0.62
7/5/2015	5:30:00 PM	0.62
7/5/2015	5:45:00 PM	0.62
7/5/2015	6:00:00 PM	0.62
7/5/2015	6:15:00 PM	0.62
7/5/2015	6:30:00 PM	0.62
7/5/2015	6:45:00 PM	0.62

Georges Ditch Return Gage

DATE	TIME	GAGE
7/5/2015	7:00:00 PM	0.62
7/5/2015	7:15:00 PM	0.66
7/5/2015	7:30:00 PM	0.69
7/5/2015	7:45:00 PM	0.71
7/5/2015	8:00:00 PM	0.72
7/5/2015	8:15:00 PM	0.72
7/5/2015	8:30:00 PM	0.72
7/5/2015	8:45:00 PM	0.72
7/5/2015	9:00:00 PM	0.72
7/5/2015	9:15:00 PM	0.72
7/5/2015	9:30:00 PM	0.73
7/5/2015	9:45:00 PM	0.73
7/5/2015	10:00:00 PM	0.73
7/5/2015	10:15:00 PM	0.73
7/5/2015	10:30:00 PM	0.73
7/5/2015	10:45:00 PM	0.73
7/5/2015	11:00:00 PM	0.73
7/5/2015	11:15:00 PM	0.73
7/5/2015	11:30:00 PM	0.73
7/5/2015	11:45:00 PM	0.73
7/6/2015	12:00:00 AM	0.73
7/6/2015	12:15:00 AM	0.73
7/6/2015	12:30:00 AM	0.73
7/6/2015	12:45:00 AM	0.73
7/6/2015	1:00:00 AM	0.73
7/6/2015	1:15:00 AM	0.73
7/6/2015	1:30:00 AM	0.73
7/6/2015	1:45:00 AM	0.73
7/6/2015	2:00:00 AM	0.73
7/6/2015	2:15:00 AM	0.73
7/6/2015	2:30:00 AM	0.73
7/6/2015	2:45:00 AM	0.73
7/6/2015	3:00:00 AM	0.73
7/6/2015	3:15:00 AM	0.73
7/6/2015	3:30:00 AM	0.73
7/6/2015	3:45:00 AM	0.73
7/6/2015	4:00:00 AM	0.73
7/6/2015	4:15:00 AM	0.73
7/6/2015	4:30:00 AM	0.73
7/6/2015	4:45:00 AM	0.73
7/6/2015	5:00:00 AM	0.73
7/6/2015	5:15:00 AM	0.73
7/6/2015	5:30:00 AM	0.73
7/6/2015	5:45:00 AM	0.73
7/6/2015	6:00:00 AM	0.73
7/6/2015	6:15:00 AM	0.73

Georges Ditch Return Gage

DATE	TIME	GAGE
7/6/2015	6:30:00 AM	0.73
7/6/2015	6:45:00 AM	0.73
7/6/2015	7:00:00 AM	0.73
7/6/2015	7:15:00 AM	0.73
7/6/2015	7:30:00 AM	0.73
7/6/2015	7:45:00 AM	0.73
7/6/2015	8:00:00 AM	0.73
7/6/2015	8:15:00 AM	0.73
7/6/2015	8:30:00 AM	0.73
7/6/2015	8:45:00 AM	0.73
7/6/2015	9:00:00 AM	0.73
7/6/2015	9:15:00 AM	0.73
7/6/2015	9:30:00 AM	0.73
7/6/2015	9:45:00 AM	0.73
7/6/2015	10:00:00 AM	0.73
7/6/2015	10:15:00 AM	0.73
7/6/2015	10:30:00 AM	0.73
7/6/2015	10:45:00 AM	0.73
7/6/2015	11:00:00 AM	0.73
7/6/2015	11:15:00 AM	0.73
7/6/2015	11:30:00 AM	0.73
7/6/2015	11:45:00 AM	0.73
7/6/2015	12:00:00 PM	0.73
7/6/2015	12:15:00 PM	0.73
7/6/2015	12:30:00 PM	0.73
7/6/2015	12:45:00 PM	0.73
7/6/2015	1:00:00 PM	0.73
7/6/2015	1:15:00 PM	0.73
7/6/2015	1:30:00 PM	0.73
7/6/2015	1:45:00 PM	0.73
7/6/2015	2:00:00 PM	0.73
7/6/2015	2:15:00 PM	0.73
7/6/2015	2:30:00 PM	0.73
7/6/2015	2:45:00 PM	0.72
7/6/2015	3:00:00 PM	0.72
7/6/2015	3:15:00 PM	0.72
7/6/2015	3:30:00 PM	0.72
7/6/2015	3:45:00 PM	0.72
7/6/2015	4:00:00 PM	0.72
7/6/2015	4:15:00 PM	0.72
7/6/2015	4:30:00 PM	0.72
7/6/2015	4:45:00 PM	0.72
7/6/2015	5:00:00 PM	0.72
7/6/2015	5:15:00 PM	0.72
7/6/2015	5:30:00 PM	0.72
7/6/2015	5:45:00 PM	0.72

Georges Ditch Return Gage

DATE	TIME	GAGE
7/6/2015	6:00:00 PM	0.72
7/6/2015	6:15:00 PM	0.72
7/6/2015	6:30:00 PM	0.72
7/6/2015	6:45:00 PM	0.72
7/6/2015	7:00:00 PM	0.72
7/6/2015	7:15:00 PM	0.72
7/6/2015	7:30:00 PM	0.72
7/6/2015	7:45:00 PM	0.72
7/6/2015	8:00:00 PM	0.72
7/6/2015	8:15:00 PM	0.72
7/6/2015	8:30:00 PM	0.72
7/6/2015	8:45:00 PM	0.72
7/6/2015	9:00:00 PM	0.72
7/6/2015	9:15:00 PM	0.72
7/6/2015	9:30:00 PM	0.72
7/6/2015	9:45:00 PM	0.72
7/6/2015	10:00:00 PM	0.72
7/6/2015	10:15:00 PM	0.72
7/6/2015	10:30:00 PM	0.72
7/6/2015	10:45:00 PM	0.72
7/6/2015	11:00:00 PM	0.72
7/6/2015	11:15:00 PM	0.72
7/6/2015	11:30:00 PM	0.72
7/6/2015	11:45:00 PM	0.72
7/7/2015	12:00:00 AM	0.72
7/7/2015	12:15:00 AM	0.72
7/7/2015	12:30:00 AM	0.72
7/7/2015	12:45:00 AM	0.72
7/7/2015	1:00:00 AM	0.72
7/7/2015	1:15:00 AM	0.72
7/7/2015	1:30:00 AM	0.72
7/7/2015	1:45:00 AM	0.73
7/7/2015	2:00:00 AM	0.72
7/7/2015	2:15:00 AM	0.72
7/7/2015	2:30:00 AM	0.72
7/7/2015	2:45:00 AM	0.72
7/7/2015	3:00:00 AM	0.72
7/7/2015	3:15:00 AM	0.73
7/7/2015	3:30:00 AM	0.72
7/7/2015	3:45:00 AM	0.72
7/7/2015	4:00:00 AM	0.72
7/7/2015	4:15:00 AM	0.72
7/7/2015	4:30:00 AM	0.72
7/7/2015	4:45:00 AM	0.72
7/7/2015	5:00:00 AM	0.73
7/7/2015	5:15:00 AM	0.73

Georges Ditch Return Gage

DATE	TIME	GAGE
7/7/2015	5:30:00 AM	0.73
7/7/2015	5:45:00 AM	0.73
7/7/2015	6:00:00 AM	0.73
7/7/2015	6:15:00 AM	0.73
7/7/2015	6:30:00 AM	0.73
7/7/2015	6:45:00 AM	0.73
7/7/2015	7:00:00 AM	0.73
7/7/2015	7:15:00 AM	0.73
7/7/2015	7:30:00 AM	0.72
7/7/2015	7:45:00 AM	0.73
7/7/2015	8:00:00 AM	0.73
7/7/2015	8:15:00 AM	0.73
7/7/2015	8:30:00 AM	0.73
7/7/2015	8:45:00 AM	0.73
7/7/2015	9:00:00 AM	0.73
7/7/2015	9:15:00 AM	0.72
7/7/2015	9:30:00 AM	0.73
7/7/2015	9:45:00 AM	0.73
7/7/2015	10:00:00 AM	0.72
7/7/2015	10:15:00 AM	0.72
7/7/2015	10:30:00 AM	0.72
7/7/2015	10:45:00 AM	0.72
7/7/2015	11:00:00 AM	0.72
7/7/2015	11:15:00 AM	0.72
7/7/2015	11:30:00 AM	0.72
7/7/2015	11:45:00 AM	0.72
7/7/2015	12:00:00 PM	0.72
7/7/2015	12:15:00 PM	0.72
7/7/2015	12:30:00 PM	0.72
7/7/2015	12:45:00 PM	0.72
7/7/2015	1:00:00 PM	0.72
7/7/2015	1:15:00 PM	0.72
7/7/2015	1:30:00 PM	0.72
7/7/2015	1:45:00 PM	0.72
7/7/2015	2:00:00 PM	0.72
7/7/2015	2:15:00 PM	0.72
7/7/2015	2:30:00 PM	0.72
7/7/2015	2:45:00 PM	0.72
7/7/2015	3:00:00 PM	0.72
7/7/2015	3:15:00 PM	0.72
7/7/2015	3:30:00 PM	0.72
7/7/2015	3:45:00 PM	0.72
7/7/2015	4:00:00 PM	0.72
7/7/2015	4:15:00 PM	0.72
7/7/2015	4:30:00 PM	0.72
7/7/2015	4:45:00 PM	0.72

Georges Ditch Return Gage

DATE	TIME	GAGE
7/7/2015	5:00:00 PM	0.72
7/7/2015	5:15:00 PM	0.71
7/7/2015	5:30:00 PM	0.71
7/7/2015	5:45:00 PM	0.71
7/7/2015	6:00:00 PM	0.71
7/7/2015	6:15:00 PM	0.71
7/7/2015	6:30:00 PM	0.71
7/7/2015	6:45:00 PM	0.71
7/7/2015	7:00:00 PM	0.71
7/7/2015	7:15:00 PM	0.71
7/7/2015	7:30:00 PM	0.71
7/7/2015	7:45:00 PM	0.71
7/7/2015	8:00:00 PM	0.71
7/7/2015	8:15:00 PM	0.71
7/7/2015	8:30:00 PM	0.71
7/7/2015	8:45:00 PM	0.71
7/7/2015	9:00:00 PM	0.71
7/7/2015	9:15:00 PM	0.71
7/7/2015	9:30:00 PM	0.71
7/7/2015	9:45:00 PM	0.71
7/7/2015	10:00:00 PM	0.71
7/7/2015	10:15:00 PM	0.72
7/7/2015	10:30:00 PM	0.72
7/7/2015	10:45:00 PM	0.72
7/7/2015	11:00:00 PM	0.72
7/7/2015	11:15:00 PM	0.72
7/7/2015	11:30:00 PM	0.72
7/7/2015	11:45:00 PM	0.72
7/8/2015	12:00:00 AM	0.72
7/8/2015	12:15:00 AM	0.72
7/8/2015	12:30:00 AM	0.72
7/8/2015	12:45:00 AM	0.72
7/8/2015	1:00:00 AM	0.72
7/8/2015	1:15:00 AM	0.72
7/8/2015	1:30:00 AM	0.72
7/8/2015	1:45:00 AM	0.72
7/8/2015	2:00:00 AM	0.72
7/8/2015	2:15:00 AM	0.72
7/8/2015	2:30:00 AM	0.72
7/8/2015	2:45:00 AM	0.72
7/8/2015	3:00:00 AM	0.72
7/8/2015	3:15:00 AM	0.72
7/8/2015	3:30:00 AM	0.72
7/8/2015	3:45:00 AM	0.72
7/8/2015	4:00:00 AM	0.72
7/8/2015	4:15:00 AM	0.72

Georges Ditch Return Gage

DATE	TIME	GAGE
7/8/2015	4:30:00 AM	0.72
7/8/2015	4:45:00 AM	0.72
7/8/2015	5:00:00 AM	0.72
7/8/2015	5:15:00 AM	0.72
7/8/2015	5:30:00 AM	0.72
7/8/2015	5:45:00 AM	0.72
7/8/2015	6:00:00 AM	0.72
7/8/2015	6:15:00 AM	0.72
7/8/2015	6:30:00 AM	0.72
7/8/2015	6:45:00 AM	0.72
7/8/2015	7:00:00 AM	0.72
7/8/2015	7:15:00 AM	0.72
7/8/2015	7:30:00 AM	0.72
7/8/2015	7:45:00 AM	0.72
7/8/2015	8:00:00 AM	0.72
7/8/2015	8:15:00 AM	0.72
7/8/2015	8:30:00 AM	0.72
7/8/2015	8:45:00 AM	0.72
7/8/2015	9:00:00 AM	0.72
7/8/2015	9:15:00 AM	0.72
7/8/2015	9:30:00 AM	0.72
7/8/2015	9:45:00 AM	0.72
7/8/2015	10:00:00 AM	0.72
7/8/2015	10:15:00 AM	0.72
7/8/2015	10:30:00 AM	0.72
7/8/2015	10:45:00 AM	0.72
7/8/2015	11:00:00 AM	0.72
7/8/2015	11:15:00 AM	0.72
7/8/2015	11:30:00 AM	0.72
7/8/2015	11:45:00 AM	0.72
7/8/2015	12:00:00 PM	0.72
7/8/2015	12:15:00 PM	0.72
7/8/2015	12:30:00 PM	0.72
7/8/2015	12:45:00 PM	0.72
7/8/2015	1:00:00 PM	0.72
7/8/2015	1:15:00 PM	0.72
7/8/2015	1:30:00 PM	0.72
7/8/2015	1:45:00 PM	0.72
7/8/2015	2:00:00 PM	0.72
7/8/2015	2:15:00 PM	0.72
7/8/2015	2:30:00 PM	0.72
7/8/2015	2:45:00 PM	0.72
7/8/2015	3:00:00 PM	0.72
7/8/2015	3:15:00 PM	0.72
7/8/2015	3:30:00 PM	0.72
7/8/2015	3:45:00 PM	0.72

Georges Ditch Return Gage

DATE	TIME	GAGE
7/8/2015	4:00:00 PM	0.71
7/8/2015	4:15:00 PM	0.66
7/8/2015	4:30:00 PM	0.57
7/8/2015	4:45:00 PM	0.49
7/8/2015	5:00:00 PM	0.44
7/8/2015	5:15:00 PM	0.42
7/8/2015	5:30:00 PM	0.42
7/8/2015	5:45:00 PM	0.42
7/8/2015	6:00:00 PM	0.41
7/8/2015	6:15:00 PM	0.41
7/8/2015	6:30:00 PM	0.41
7/8/2015	6:45:00 PM	0.41
7/8/2015	7:00:00 PM	0.41
7/8/2015	7:15:00 PM	0.41
7/8/2015	7:30:00 PM	0.41
7/8/2015	7:45:00 PM	0.41
7/8/2015	8:00:00 PM	0.41
7/8/2015	8:15:00 PM	0.41
7/8/2015	8:30:00 PM	0.41
7/8/2015	8:45:00 PM	0.41
7/8/2015	9:00:00 PM	0.41
7/8/2015	9:15:00 PM	0.41
7/8/2015	9:30:00 PM	0.41
7/8/2015	9:45:00 PM	0.41
7/8/2015	10:00:00 PM	0.41
7/8/2015	10:15:00 PM	0.41
7/8/2015	10:30:00 PM	0.41
7/8/2015	10:45:00 PM	0.41
7/8/2015	11:00:00 PM	0.41
7/8/2015	11:15:00 PM	0.41
7/8/2015	11:30:00 PM	0.41
7/8/2015	11:45:00 PM	0.41
7/9/2015	12:00:00 AM	0.41
7/9/2015	12:15:00 AM	0.41
7/9/2015	12:30:00 AM	0.41
7/9/2015	12:45:00 AM	0.41
7/9/2015	1:00:00 AM	0.41
7/9/2015	1:15:00 AM	0.41
7/9/2015	1:30:00 AM	0.41
7/9/2015	1:45:00 AM	0.41
7/9/2015	2:00:00 AM	0.41
7/9/2015	2:15:00 AM	0.41
7/9/2015	2:30:00 AM	0.41
7/9/2015	2:45:00 AM	0.41
7/9/2015	3:00:00 AM	0.41
7/9/2015	3:15:00 AM	0.41

Georges Ditch Return Gage

DATE	TIME	GAGE
7/9/2015	3:30:00 AM	0.41
7/9/2015	3:45:00 AM	0.41
7/9/2015	4:00:00 AM	0.41
7/9/2015	4:15:00 AM	0.41
7/9/2015	4:30:00 AM	0.41
7/9/2015	4:45:00 AM	0.41
7/9/2015	5:00:00 AM	0.41
7/9/2015	5:15:00 AM	0.41
7/9/2015	5:30:00 AM	0.41
7/9/2015	5:45:00 AM	0.41
7/9/2015	6:00:00 AM	0.41
7/9/2015	6:15:00 AM	0.41
7/9/2015	6:30:00 AM	0.41
7/9/2015	6:45:00 AM	0.41
7/9/2015	7:00:00 AM	0.41
7/9/2015	7:15:00 AM	0.41
7/9/2015	7:30:00 AM	0.41
7/9/2015	7:45:00 AM	0.41
7/9/2015	8:00:00 AM	0.41
7/9/2015	8:15:00 AM	0.41
7/9/2015	8:30:00 AM	0.41
7/9/2015	8:45:00 AM	0.41
7/9/2015	9:00:00 AM	0.41
7/9/2015	9:15:00 AM	0.41
7/9/2015	9:30:00 AM	0.41
7/9/2015	9:45:00 AM	0.41
7/9/2015	10:00:00 AM	0.41
7/9/2015	10:15:00 AM	0.41
7/9/2015	10:30:00 AM	0.4
7/9/2015	10:45:00 AM	0.4
7/9/2015	11:00:00 AM	0.4
7/9/2015	11:15:00 AM	0.4
7/9/2015	11:30:00 AM	0.4
7/9/2015	11:45:00 AM	0.4
7/9/2015	12:00:00 PM	0.4
7/9/2015	12:15:00 PM	0.4
7/9/2015	12:30:00 PM	0.4
7/9/2015	12:45:00 PM	0.39
7/9/2015	1:00:00 PM	0.39
7/9/2015	1:15:00 PM	0.39
7/9/2015	1:30:00 PM	0.39
7/9/2015	1:45:00 PM	0.39
7/9/2015	2:00:00 PM	0.39
7/9/2015	2:15:00 PM	0.39
7/9/2015	2:30:00 PM	0.39
7/9/2015	2:45:00 PM	0.39

Georges Ditch Return Gage

DATE	TIME	GAGE
7/9/2015	3:00:00 PM	0.39
7/9/2015	3:15:00 PM	0.39
7/9/2015	3:30:00 PM	0.38
7/9/2015	3:45:00 PM	0.38
7/9/2015	4:00:00 PM	0.38
7/9/2015	4:15:00 PM	0.38
7/9/2015	4:30:00 PM	0.38
7/9/2015	4:45:00 PM	0.38
7/9/2015	5:00:00 PM	0.38
7/9/2015	5:15:00 PM	0.38
7/9/2015	5:30:00 PM	0.38
7/9/2015	5:45:00 PM	0.38
7/9/2015	6:00:00 PM	0.38
7/9/2015	6:15:00 PM	0.38
7/9/2015	6:30:00 PM	0.38
7/9/2015	6:45:00 PM	0.39
7/9/2015	7:00:00 PM	0.39
7/9/2015	7:15:00 PM	0.39
7/9/2015	7:30:00 PM	0.39
7/9/2015	7:45:00 PM	0.39
7/9/2015	8:00:00 PM	0.39
7/9/2015	8:15:00 PM	0.39
7/9/2015	8:30:00 PM	0.39
7/9/2015	8:45:00 PM	0.39
7/9/2015	9:00:00 PM	0.39
7/9/2015	9:15:00 PM	0.39
7/9/2015	9:30:00 PM	0.39
7/9/2015	9:45:00 PM	0.39
7/9/2015	10:00:00 PM	0.39
7/9/2015	10:15:00 PM	0.39
7/9/2015	10:30:00 PM	0.39
7/9/2015	10:45:00 PM	0.39
7/9/2015	11:00:00 PM	0.39
7/9/2015	11:15:00 PM	0.4
7/9/2015	11:30:00 PM	0.4
7/9/2015	11:45:00 PM	0.4
7/10/2015	12:00:00 AM	0.4
7/10/2015	12:15:00 AM	0.4
7/10/2015	12:30:00 AM	0.4
7/10/2015	12:45:00 AM	0.4
7/10/2015	1:00:00 AM	0.4
7/10/2015	1:15:00 AM	0.4
7/10/2015	1:30:00 AM	0.4
7/10/2015	1:45:00 AM	0.4
7/10/2015	2:00:00 AM	0.4
7/10/2015	2:15:00 AM	0.4

Georges Ditch Return Gage

DATE	TIME	GAGE
7/10/2015	2:30:00 AM	0.4
7/10/2015	2:45:00 AM	0.4
7/10/2015	3:00:00 AM	0.4
7/10/2015	3:15:00 AM	0.4
7/10/2015	3:30:00 AM	0.4
7/10/2015	3:45:00 AM	0.4
7/10/2015	4:00:00 AM	0.4
7/10/2015	4:15:00 AM	0.4
7/10/2015	4:30:00 AM	0.4
7/10/2015	4:45:00 AM	0.4
7/10/2015	5:00:00 AM	0.4
7/10/2015	5:15:00 AM	0.4
7/10/2015	5:30:00 AM	0.4
7/10/2015	5:45:00 AM	0.4
7/10/2015	6:00:00 AM	0.4
7/10/2015	6:15:00 AM	0.4
7/10/2015	6:30:00 AM	0.4
7/10/2015	6:45:00 AM	0.4
7/10/2015	7:00:00 AM	0.4
7/10/2015	7:15:00 AM	0.4
7/10/2015	7:30:00 AM	0.4
7/10/2015	7:45:00 AM	0.4
7/10/2015	8:00:00 AM	0.4
7/10/2015	8:15:00 AM	0.4
7/10/2015	8:30:00 AM	0.4
7/10/2015	8:45:00 AM	0.4
7/10/2015	9:00:00 AM	0.4
7/10/2015	9:15:00 AM	0.4
7/10/2015	9:30:00 AM	0.4
7/10/2015	9:45:00 AM	0.4
7/10/2015	10:00:00 AM	0.39
7/10/2015	10:15:00 AM	0.39
7/10/2015	10:30:00 AM	0.39
7/10/2015	10:45:00 AM	0.39
7/10/2015	11:00:00 AM	0.39
7/10/2015	11:15:00 AM	0.39
7/10/2015	11:30:00 AM	0.39
7/10/2015	11:45:00 AM	0.39
7/10/2015	12:00:00 PM	0.4
7/10/2015	12:15:00 PM	0.44
7/10/2015	12:30:00 PM	0.47
7/10/2015	12:45:00 PM	0.48
7/10/2015	1:00:00 PM	0.49
7/10/2015	1:15:00 PM	0.49
7/10/2015	1:30:00 PM	0.49
7/10/2015	1:45:00 PM	0.48

Georges Ditch Return Gage

DATE	TIME	GAGE
7/10/2015	2:00:00 PM	0.48
7/10/2015	2:15:00 PM	0.48
7/10/2015	2:30:00 PM	0.48
7/10/2015	2:45:00 PM	0.48
7/10/2015	3:00:00 PM	0.48
7/10/2015	3:15:00 PM	0.48
7/10/2015	3:30:00 PM	0.48
7/10/2015	3:45:00 PM	0.48
7/10/2015	4:00:00 PM	0.48
7/10/2015	4:15:00 PM	0.48
7/10/2015	4:30:00 PM	0.48
7/10/2015	4:45:00 PM	0.48
7/10/2015	5:00:00 PM	0.48
7/10/2015	5:15:00 PM	0.48
7/10/2015	5:30:00 PM	0.48
7/10/2015	5:45:00 PM	0.48
7/10/2015	6:00:00 PM	0.48
7/10/2015	6:15:00 PM	0.48
7/10/2015	6:30:00 PM	0.48
7/10/2015	6:45:00 PM	0.48
7/10/2015	7:00:00 PM	0.48
7/10/2015	7:15:00 PM	0.48
7/10/2015	7:30:00 PM	0.48
7/10/2015	7:45:00 PM	0.48
7/10/2015	8:00:00 PM	0.48
7/10/2015	8:15:00 PM	0.48
7/10/2015	8:30:00 PM	0.48
7/10/2015	8:45:00 PM	0.48
7/10/2015	9:00:00 PM	0.48
7/10/2015	9:15:00 PM	0.48
7/10/2015	9:30:00 PM	0.48
7/10/2015	9:45:00 PM	0.48
7/10/2015	10:00:00 PM	0.48
7/10/2015	10:15:00 PM	0.48
7/10/2015	10:30:00 PM	0.48
7/10/2015	10:45:00 PM	0.48
7/10/2015	11:00:00 PM	0.48
7/10/2015	11:15:00 PM	0.48
7/10/2015	11:30:00 PM	0.48
7/10/2015	11:45:00 PM	0.48
7/11/2015	12:00:00 AM	0.48
7/11/2015	12:15:00 AM	0.48
7/11/2015	12:30:00 AM	0.48
7/11/2015	12:45:00 AM	0.48
7/11/2015	1:00:00 AM	0.48
7/11/2015	1:15:00 AM	0.48

Georges Ditch Return Gage

DATE	TIME	GAGE
7/11/2015	1:30:00 AM	0.48
7/11/2015	1:45:00 AM	0.48
7/11/2015	2:00:00 AM	0.48
7/11/2015	2:15:00 AM	0.48
7/11/2015	2:30:00 AM	0.48
7/11/2015	2:45:00 AM	0.48
7/11/2015	3:00:00 AM	0.48
7/11/2015	3:15:00 AM	0.48
7/11/2015	3:30:00 AM	0.48
7/11/2015	3:45:00 AM	0.48
7/11/2015	4:00:00 AM	0.48
7/11/2015	4:15:00 AM	0.48
7/11/2015	4:30:00 AM	0.48
7/11/2015	4:45:00 AM	0.48
7/11/2015	5:00:00 AM	0.48
7/11/2015	5:15:00 AM	0.48
7/11/2015	5:30:00 AM	0.48
7/11/2015	5:45:00 AM	0.48
7/11/2015	6:00:00 AM	0.48
7/11/2015	6:15:00 AM	0.48
7/11/2015	6:30:00 AM	0.48
7/11/2015	6:45:00 AM	0.48
7/11/2015	7:00:00 AM	0.48
7/11/2015	7:15:00 AM	0.48
7/11/2015	7:30:00 AM	0.48
7/11/2015	7:45:00 AM	0.48
7/11/2015	8:00:00 AM	0.48
7/11/2015	8:15:00 AM	0.48
7/11/2015	8:30:00 AM	0.48
7/11/2015	8:45:00 AM	0.48
7/11/2015	9:00:00 AM	0.48
7/11/2015	9:15:00 AM	0.48
7/11/2015	9:30:00 AM	0.48
7/11/2015	9:45:00 AM	0.48
7/11/2015	10:00:00 AM	0.48
7/11/2015	10:15:00 AM	0.48
7/11/2015	10:30:00 AM	0.48
7/11/2015	10:45:00 AM	0.48
7/11/2015	11:00:00 AM	0.48
7/11/2015	11:15:00 AM	0.48
7/11/2015	11:30:00 AM	0.48
7/11/2015	11:45:00 AM	0.48
7/11/2015	12:00:00 PM	0.48
7/11/2015	12:15:00 PM	0.48
7/11/2015	12:30:00 PM	0.48
7/11/2015	12:45:00 PM	0.48

Georges Ditch Return Gage

DATE	TIME	GAGE
7/11/2015	1:00:00 PM	0.48
7/11/2015	1:15:00 PM	0.48
7/11/2015	1:30:00 PM	0.48
7/11/2015	1:45:00 PM	0.47
7/11/2015	2:00:00 PM	0.46
7/11/2015	2:15:00 PM	0.45
7/11/2015	2:30:00 PM	0.45
7/11/2015	2:45:00 PM	0.45
7/11/2015	3:00:00 PM	0.45
7/11/2015	3:15:00 PM	0.45
7/11/2015	3:30:00 PM	0.45
7/11/2015	3:45:00 PM	0.45
7/11/2015	4:00:00 PM	0.45
7/11/2015	4:15:00 PM	0.45
7/11/2015	4:30:00 PM	0.45
7/11/2015	4:45:00 PM	0.45
7/11/2015	5:00:00 PM	0.44
7/11/2015	5:15:00 PM	0.44
7/11/2015	5:30:00 PM	0.44
7/11/2015	5:45:00 PM	0.44
7/11/2015	6:00:00 PM	0.44
7/11/2015	6:15:00 PM	0.44
7/11/2015	6:30:00 PM	0.44
7/11/2015	6:45:00 PM	0.44
7/11/2015	7:00:00 PM	0.44
7/11/2015	7:15:00 PM	0.44
7/11/2015	7:30:00 PM	0.43
7/11/2015	7:45:00 PM	0.43
7/11/2015	8:00:00 PM	0.43
7/11/2015	8:15:00 PM	0.43
7/11/2015	8:30:00 PM	0.43
7/11/2015	8:45:00 PM	0.43
7/11/2015	9:00:00 PM	0.43
7/11/2015	9:15:00 PM	0.43
7/11/2015	9:30:00 PM	0.43
7/11/2015	9:45:00 PM	0.43
7/11/2015	10:00:00 PM	0.43
7/11/2015	10:15:00 PM	0.43
7/11/2015	10:30:00 PM	0.43
7/11/2015	10:45:00 PM	0.43
7/11/2015	11:00:00 PM	0.43
7/11/2015	11:15:00 PM	0.43
7/11/2015	11:30:00 PM	0.43
7/11/2015	11:45:00 PM	0.44
7/12/2015	12:00:00 AM	0.44
7/12/2015	12:15:00 AM	0.44

Georges Ditch Return Gage

DATE	TIME	GAGE
7/12/2015	12:30:00 AM	0.44
7/12/2015	12:45:00 AM	0.44
7/12/2015	1:00:00 AM	0.44
7/12/2015	1:15:00 AM	0.44
7/12/2015	1:30:00 AM	0.44
7/12/2015	1:45:00 AM	0.44
7/12/2015	2:00:00 AM	0.44
7/12/2015	2:15:00 AM	0.44
7/12/2015	2:30:00 AM	0.44
7/12/2015	2:45:00 AM	0.44
7/12/2015	3:00:00 AM	0.44
7/12/2015	3:15:00 AM	0.44
7/12/2015	3:30:00 AM	0.44
7/12/2015	3:45:00 AM	0.44
7/12/2015	4:00:00 AM	0.44
7/12/2015	4:15:00 AM	0.44
7/12/2015	4:30:00 AM	0.44
7/12/2015	4:45:00 AM	0.44
7/12/2015	5:00:00 AM	0.44
7/12/2015	5:15:00 AM	0.44
7/12/2015	5:30:00 AM	0.44
7/12/2015	5:45:00 AM	0.44
7/12/2015	6:00:00 AM	0.44
7/12/2015	6:15:00 AM	0.44
7/12/2015	6:30:00 AM	0.44
7/12/2015	6:45:00 AM	0.44
7/12/2015	7:00:00 AM	0.44
7/12/2015	7:15:00 AM	0.44
7/12/2015	7:30:00 AM	0.44
7/12/2015	7:45:00 AM	0.44
7/12/2015	8:00:00 AM	0.44
7/12/2015	8:15:00 AM	0.44
7/12/2015	8:30:00 AM	0.44
7/12/2015	8:45:00 AM	0.44
7/12/2015	9:00:00 AM	0.44
7/12/2015	9:15:00 AM	0.44
7/12/2015	9:30:00 AM	0.44
7/12/2015	9:45:00 AM	0.44
7/12/2015	10:00:00 AM	0.44
7/12/2015	10:15:00 AM	0.44
7/12/2015	10:30:00 AM	0.44
7/12/2015	10:45:00 AM	0.44
7/12/2015	11:00:00 AM	0.44
7/12/2015	11:15:00 AM	0.44
7/12/2015	11:30:00 AM	0.44
7/12/2015	11:45:00 AM	0.44

Georges Ditch Return Gage

DATE	TIME	GAGE
7/12/2015	12:00:00 PM	0.44
7/12/2015	12:15:00 PM	0.44
7/12/2015	12:30:00 PM	0.44
7/12/2015	12:45:00 PM	0.44
7/12/2015	1:00:00 PM	0.44
7/12/2015	1:15:00 PM	0.44
7/12/2015	1:30:00 PM	0.44
7/12/2015	1:45:00 PM	0.44
7/12/2015	2:00:00 PM	0.44
7/12/2015	2:15:00 PM	0.44
7/12/2015	2:30:00 PM	0.44
7/12/2015	2:45:00 PM	0.44
7/12/2015	3:00:00 PM	0.44
7/12/2015	3:15:00 PM	0.44
7/12/2015	3:30:00 PM	0.44
7/12/2015	3:45:00 PM	0.44
7/12/2015	4:00:00 PM	0.44
7/12/2015	4:15:00 PM	0.44
7/12/2015	4:30:00 PM	0.44
7/12/2015	4:45:00 PM	0.43
7/12/2015	5:00:00 PM	0.43
7/12/2015	5:15:00 PM	0.43
7/12/2015	5:30:00 PM	0.43
7/12/2015	5:45:00 PM	0.43
7/12/2015	6:00:00 PM	0.43
7/12/2015	6:15:00 PM	0.43
7/12/2015	6:30:00 PM	0.43
7/12/2015	6:45:00 PM	0.43
7/12/2015	7:00:00 PM	0.43
7/12/2015	7:15:00 PM	0.43
7/12/2015	7:30:00 PM	0.43
7/12/2015	7:45:00 PM	0.43
7/12/2015	8:00:00 PM	0.43
7/12/2015	8:15:00 PM	0.43
7/12/2015	8:30:00 PM	0.43
7/12/2015	8:45:00 PM	0.43
7/12/2015	9:00:00 PM	0.43
7/12/2015	9:15:00 PM	0.43
7/12/2015	9:30:00 PM	0.43
7/12/2015	9:45:00 PM	0.43
7/12/2015	10:00:00 PM	0.43
7/12/2015	10:15:00 PM	0.43
7/12/2015	10:30:00 PM	0.43
7/12/2015	10:45:00 PM	0.43
7/12/2015	11:00:00 PM	0.43
7/12/2015	11:15:00 PM	0.43

Georges Ditch Return Gage

DATE	TIME	GAGE
7/12/2015	11:30:00 PM	0.43
7/12/2015	11:45:00 PM	0.43
7/13/2015	12:00:00 AM	0.43
7/13/2015	12:15:00 AM	0.43
7/13/2015	12:30:00 AM	0.44
7/13/2015	12:45:00 AM	0.44
7/13/2015	1:00:00 AM	0.44
7/13/2015	1:15:00 AM	0.44
7/13/2015	1:30:00 AM	0.44
7/13/2015	1:45:00 AM	0.44
7/13/2015	2:00:00 AM	0.44
7/13/2015	2:15:00 AM	0.44
7/13/2015	2:30:00 AM	0.44
7/13/2015	2:45:00 AM	0.44
7/13/2015	3:00:00 AM	0.44
7/13/2015	3:15:00 AM	0.44
7/13/2015	3:30:00 AM	0.44
7/13/2015	3:45:00 AM	0.44
7/13/2015	4:00:00 AM	0.44
7/13/2015	4:15:00 AM	0.44
7/13/2015	4:30:00 AM	0.44
7/13/2015	4:45:00 AM	0.44
7/13/2015	5:00:00 AM	0.44
7/13/2015	5:15:00 AM	0.44
7/13/2015	5:30:00 AM	0.44
7/13/2015	5:45:00 AM	0.44
7/13/2015	6:00:00 AM	0.44
7/13/2015	6:15:00 AM	0.44
7/13/2015	6:30:00 AM	0.44
7/13/2015	6:45:00 AM	0.44
7/13/2015	7:00:00 AM	0.44
7/13/2015	7:15:00 AM	0.44
7/13/2015	7:30:00 AM	0.44
7/13/2015	7:45:00 AM	0.44
7/13/2015	8:00:00 AM	0.44
7/13/2015	8:15:00 AM	0.44
7/13/2015	8:30:00 AM	0.44
7/13/2015	8:45:00 AM	0.44
7/13/2015	9:00:00 AM	0.44
7/13/2015	9:15:00 AM	0.44
7/13/2015	9:30:00 AM	0.44
7/13/2015	9:45:00 AM	0.44
7/13/2015	10:00:00 AM	0.44
7/13/2015	10:15:00 AM	0.44
7/13/2015	10:30:00 AM	0.44
7/13/2015	10:45:00 AM	0.44

Georges Ditch Return Gage

DATE	TIME	GAGE
7/13/2015	11:00:00 AM	0.44
7/13/2015	11:15:00 AM	0.44
7/13/2015	11:30:00 AM	0.44
7/13/2015	11:45:00 AM	0.44
7/13/2015	12:00:00 PM	0.44
7/13/2015	12:15:00 PM	0.44
7/13/2015	12:30:00 PM	0.44
7/13/2015	12:45:00 PM	0.44
7/13/2015	1:00:00 PM	0.44
7/13/2015	1:15:00 PM	0.44
7/13/2015	1:30:00 PM	0.44
7/13/2015	1:45:00 PM	0.44
7/13/2015	2:00:00 PM	0.43
7/13/2015	2:15:00 PM	0.43
7/13/2015	2:30:00 PM	0.43
7/13/2015	2:45:00 PM	0.43
7/13/2015	3:00:00 PM	0.44
7/13/2015	3:15:00 PM	0.52
7/13/2015	3:30:00 PM	0.61
7/13/2015	3:45:00 PM	0.68
7/13/2015	4:00:00 PM	0.71
7/13/2015	4:15:00 PM	0.72
7/13/2015	4:30:00 PM	0.72
7/13/2015	4:45:00 PM	0.73
7/13/2015	5:00:00 PM	0.73
7/13/2015	5:15:00 PM	0.73
7/13/2015	5:30:00 PM	0.73
7/13/2015	5:45:00 PM	0.73
7/13/2015	6:00:00 PM	0.73
7/13/2015	6:15:00 PM	0.73
7/13/2015	6:30:00 PM	0.73
7/13/2015	6:45:00 PM	0.72
7/13/2015	7:00:00 PM	0.72
7/13/2015	7:15:00 PM	0.72
7/13/2015	7:30:00 PM	0.72
7/13/2015	7:45:00 PM	0.72
7/13/2015	8:00:00 PM	0.72
7/13/2015	8:15:00 PM	0.72
7/13/2015	8:30:00 PM	0.72
7/13/2015	8:45:00 PM	0.72
7/13/2015	9:00:00 PM	0.72
7/13/2015	9:15:00 PM	0.72
7/13/2015	9:30:00 PM	0.72
7/13/2015	9:45:00 PM	0.72
7/13/2015	10:00:00 PM	0.72
7/13/2015	10:15:00 PM	0.72

Georges Ditch Return Gage

DATE	TIME	GAGE
7/13/2015	10:30:00 PM	0.72
7/13/2015	10:45:00 PM	0.72
7/13/2015	11:00:00 PM	0.72
7/13/2015	11:15:00 PM	0.72
7/13/2015	11:30:00 PM	0.72
7/13/2015	11:45:00 PM	0.72
7/14/2015	12:00:00 AM	0.72
7/14/2015	12:15:00 AM	0.72
7/14/2015	12:30:00 AM	0.72
7/14/2015	12:45:00 AM	0.72
7/14/2015	1:00:00 AM	0.72
7/14/2015	1:15:00 AM	0.72
7/14/2015	1:30:00 AM	0.72
7/14/2015	1:45:00 AM	0.72
7/14/2015	2:00:00 AM	0.72
7/14/2015	2:15:00 AM	0.72
7/14/2015	2:30:00 AM	0.72
7/14/2015	2:45:00 AM	0.72
7/14/2015	3:00:00 AM	0.72
7/14/2015	3:15:00 AM	0.72
7/14/2015	3:30:00 AM	0.72
7/14/2015	3:45:00 AM	0.72
7/14/2015	4:00:00 AM	0.72
7/14/2015	4:15:00 AM	0.72
7/14/2015	4:30:00 AM	0.72
7/14/2015	4:45:00 AM	0.72
7/14/2015	5:00:00 AM	0.72
7/14/2015	5:15:00 AM	0.72
7/14/2015	5:30:00 AM	0.72
7/14/2015	5:45:00 AM	0.72
7/14/2015	6:00:00 AM	0.72
7/14/2015	6:15:00 AM	0.72
7/14/2015	6:30:00 AM	0.72
7/14/2015	6:45:00 AM	0.72
7/14/2015	7:00:00 AM	0.73
7/14/2015	7:15:00 AM	0.73
7/14/2015	7:30:00 AM	0.73
7/14/2015	7:45:00 AM	0.73
7/14/2015	8:00:00 AM	0.73
7/14/2015	8:15:00 AM	0.73
7/14/2015	8:30:00 AM	0.73
7/14/2015	8:45:00 AM	0.73
7/14/2015	9:00:00 AM	0.73
7/14/2015	9:15:00 AM	0.73
7/14/2015	9:30:00 AM	0.73
7/14/2015	9:45:00 AM	0.73

Georges Ditch Return Gage

DATE	TIME	GAGE
7/14/2015	10:00:00 AM	0.73
7/14/2015	10:15:00 AM	0.73
7/14/2015	10:30:00 AM	0.73
7/14/2015	10:45:00 AM	0.73
7/14/2015	11:00:00 AM	0.73
7/14/2015	11:15:00 AM	0.73
7/14/2015	11:30:00 AM	0.73
7/14/2015	11:45:00 AM	0.73
7/14/2015	12:00:00 PM	0.73
7/14/2015	12:15:00 PM	0.73
7/14/2015	12:30:00 PM	0.73
7/14/2015	12:45:00 PM	0.73
7/14/2015	1:00:00 PM	0.73
7/14/2015	1:15:00 PM	0.72
7/14/2015	1:30:00 PM	0.72
7/14/2015	1:45:00 PM	0.72
7/14/2015	2:00:00 PM	0.72
7/14/2015	2:15:00 PM	0.72
7/14/2015	2:30:00 PM	0.72
7/14/2015	2:45:00 PM	0.72
7/14/2015	3:00:00 PM	0.72
7/14/2015	3:15:00 PM	0.72
7/14/2015	3:30:00 PM	0.72
7/14/2015	3:45:00 PM	0.73
7/14/2015	4:00:00 PM	0.73
7/14/2015	4:15:00 PM	0.73
7/14/2015	4:30:00 PM	0.73
7/14/2015	4:45:00 PM	0.73
7/14/2015	5:00:00 PM	0.72
7/14/2015	5:15:00 PM	0.73
7/14/2015	5:30:00 PM	0.73
7/14/2015	5:45:00 PM	0.73
7/14/2015	6:00:00 PM	0.72
7/14/2015	6:15:00 PM	0.72
7/14/2015	6:30:00 PM	0.72
7/14/2015	6:45:00 PM	0.72
7/14/2015	7:00:00 PM	0.72
7/14/2015	7:15:00 PM	0.72
7/14/2015	7:30:00 PM	0.72
7/14/2015	7:45:00 PM	0.72
7/14/2015	8:00:00 PM	0.72
7/14/2015	8:15:00 PM	0.71
7/14/2015	8:30:00 PM	0.71
7/14/2015	8:45:00 PM	0.71
7/14/2015	9:00:00 PM	0.71
7/14/2015	9:15:00 PM	0.71

Georges Ditch Return Gage

DATE	TIME	GAGE
7/14/2015	9:30:00 PM	0.71
7/14/2015	9:45:00 PM	0.71
7/14/2015	10:00:00 PM	0.7
7/14/2015	10:15:00 PM	0.69
7/14/2015	10:30:00 PM	0.69
7/14/2015	10:45:00 PM	0.69
7/14/2015	11:00:00 PM	0.69
7/14/2015	11:15:00 PM	0.69
7/14/2015	11:30:00 PM	0.69
7/14/2015	11:45:00 PM	0.69
7/15/2015	12:00:00 AM	0.69
7/15/2015	12:15:00 AM	0.69
7/15/2015	12:30:00 AM	0.69
7/15/2015	12:45:00 AM	0.69
7/15/2015	1:00:00 AM	0.69
7/15/2015	1:15:00 AM	0.69
7/15/2015	1:30:00 AM	0.69
7/15/2015	1:45:00 AM	0.69
7/15/2015	2:00:00 AM	0.69
7/15/2015	2:15:00 AM	0.69
7/15/2015	2:30:00 AM	0.69
7/15/2015	2:45:00 AM	0.69
7/15/2015	3:00:00 AM	0.69
7/15/2015	3:15:00 AM	0.69
7/15/2015	3:30:00 AM	0.69
7/15/2015	3:45:00 AM	0.69
7/15/2015	4:00:00 AM	0.69
7/15/2015	4:15:00 AM	0.69
7/15/2015	4:30:00 AM	0.69
7/15/2015	4:45:00 AM	0.69
7/15/2015	5:00:00 AM	0.69
7/15/2015	5:15:00 AM	0.69
7/15/2015	5:30:00 AM	0.69
7/15/2015	5:45:00 AM	0.69
7/15/2015	6:00:00 AM	0.69
7/15/2015	6:15:00 AM	0.69
7/15/2015	6:30:00 AM	0.69
7/15/2015	6:45:00 AM	0.69
7/15/2015	7:00:00 AM	0.69
7/15/2015	7:15:00 AM	0.69
7/15/2015	7:30:00 AM	0.69
7/15/2015	7:45:00 AM	0.69
7/15/2015	8:00:00 AM	0.69
7/15/2015	8:15:00 AM	0.69
7/15/2015	8:30:00 AM	0.69
7/15/2015	8:45:00 AM	0.69

Georges Ditch Return Gage

DATE	TIME	GAGE
7/15/2015	9:00:00 AM	0.69
7/15/2015	9:15:00 AM	0.69
7/15/2015	9:30:00 AM	0.69
7/15/2015	9:45:00 AM	0.69
7/15/2015	10:00:00 AM	0.69
7/15/2015	10:15:00 AM	0.69
7/15/2015	10:30:00 AM	0.69
7/15/2015	10:45:00 AM	0.69
7/15/2015	11:00:00 AM	0.69
7/15/2015	11:15:00 AM	0.69
7/15/2015	11:30:00 AM	0.69
7/15/2015	11:45:00 AM	0.69
7/15/2015	12:00:00 PM	0.69
7/15/2015	12:15:00 PM	0.69
7/15/2015	12:30:00 PM	0.69
7/15/2015	12:45:00 PM	0.69
7/15/2015	1:00:00 PM	0.69
7/15/2015	1:15:00 PM	0.73
7/15/2015	1:30:00 PM	0.73
7/15/2015	1:45:00 PM	0.73
7/15/2015	2:00:00 PM	0.73
7/15/2015	2:15:00 PM	0.73
7/15/2015	2:30:00 PM	0.72
7/15/2015	2:45:00 PM	0.73
7/15/2015	3:00:00 PM	0.73
7/15/2015	3:15:00 PM	0.73
7/15/2015	3:30:00 PM	0.72
7/15/2015	3:45:00 PM	0.72
7/15/2015	4:00:00 PM	0.72
7/15/2015	4:15:00 PM	0.72
7/15/2015	4:30:00 PM	0.72
7/15/2015	4:45:00 PM	0.72
7/15/2015	5:00:00 PM	0.72
7/15/2015	5:15:00 PM	0.72
7/15/2015	5:30:00 PM	0.72
7/15/2015	5:45:00 PM	0.71
7/15/2015	6:00:00 PM	0.71
7/15/2015	6:15:00 PM	0.71
7/15/2015	6:30:00 PM	0.71
7/15/2015	6:45:00 PM	0.71
7/15/2015	7:00:00 PM	0.71
7/15/2015	7:15:00 PM	0.71
7/15/2015	7:30:00 PM	0.7
7/15/2015	7:45:00 PM	0.69
7/15/2015	8:00:00 PM	0.69
7/15/2015	8:15:00 PM	0.69

Georges Ditch Return Gage

DATE	TIME	GAGE
7/15/2015	8:30:00 PM	0.69
7/15/2015	8:45:00 PM	0.69
7/15/2015	9:00:00 PM	0.69
7/15/2015	9:15:00 PM	0.69
7/15/2015	9:30:00 PM	0.69
7/15/2015	9:45:00 PM	0.69
7/15/2015	10:00:00 PM	0.69
7/15/2015	10:15:00 PM	0.69
7/15/2015	10:30:00 PM	0.69
7/15/2015	10:45:00 PM	0.69
7/15/2015	11:00:00 PM	0.69
7/15/2015	11:15:00 PM	0.69
7/15/2015	11:30:00 PM	0.69
7/15/2015	11:45:00 PM	0.69
7/16/2015	12:00:00 AM	0.69
7/16/2015	12:15:00 AM	0.69
7/16/2015	12:30:00 AM	0.69
7/16/2015	12:45:00 AM	0.69
7/16/2015	1:00:00 AM	0.69
7/16/2015	1:15:00 AM	0.69
7/16/2015	1:30:00 AM	0.69
7/16/2015	1:45:00 AM	0.69
7/16/2015	2:00:00 AM	0.69
7/16/2015	2:15:00 AM	0.69
7/16/2015	2:30:00 AM	0.69
7/16/2015	2:45:00 AM	0.69
7/16/2015	3:00:00 AM	0.69
7/16/2015	3:15:00 AM	0.69
7/16/2015	3:30:00 AM	0.69
7/16/2015	3:45:00 AM	0.69
7/16/2015	4:00:00 AM	0.69
7/16/2015	4:15:00 AM	0.69
7/16/2015	4:30:00 AM	0.69
7/16/2015	4:45:00 AM	0.69
7/16/2015	5:00:00 AM	0.69
7/16/2015	5:15:00 AM	0.69
7/16/2015	5:30:00 AM	0.69
7/16/2015	5:45:00 AM	0.69
7/16/2015	6:00:00 AM	0.69
7/16/2015	6:15:00 AM	0.69
7/16/2015	6:30:00 AM	0.69
7/16/2015	6:45:00 AM	0.69
7/16/2015	7:00:00 AM	0.69
7/16/2015	7:15:00 AM	0.69
7/16/2015	7:30:00 AM	0.69
7/16/2015	7:45:00 AM	0.69

Georges Ditch Return Gage

DATE	TIME	GAGE
7/16/2015	8:00:00 AM	0.69
7/16/2015	8:15:00 AM	0.69
7/16/2015	8:30:00 AM	0.69
7/16/2015	8:45:00 AM	0.69
7/16/2015	9:00:00 AM	0.69
7/16/2015	9:15:00 AM	0.69
7/16/2015	9:30:00 AM	0.69
7/16/2015	9:45:00 AM	0.69
7/16/2015	10:00:00 AM	0.69
7/16/2015	10:15:00 AM	0.69
7/16/2015	10:30:00 AM	0.69
7/16/2015	10:45:00 AM	0.69
7/16/2015	11:00:00 AM	0.69
7/16/2015	11:15:00 AM	0.69
7/16/2015	11:30:00 AM	0.69
7/16/2015	11:45:00 AM	0.69
7/16/2015	12:00:00 PM	0.69
7/16/2015	12:15:00 PM	0.69
7/16/2015	12:30:00 PM	0.69
7/16/2015	12:45:00 PM	0.69
7/16/2015	1:00:00 PM	0.69
7/16/2015	1:15:00 PM	0.69
7/16/2015	1:30:00 PM	0.68
7/16/2015	1:45:00 PM	0.68
7/16/2015	2:00:00 PM	0.68
7/16/2015	2:15:00 PM	0.68
7/16/2015	2:30:00 PM	0.68
7/16/2015	2:45:00 PM	0.69
7/16/2015	3:00:00 PM	0.69
7/16/2015	3:15:00 PM	0.69
7/16/2015	3:30:00 PM	0.69
7/16/2015	3:45:00 PM	0.69
7/16/2015	4:00:00 PM	0.69
7/16/2015	4:15:00 PM	0.69
7/16/2015	4:30:00 PM	0.69
7/16/2015	4:45:00 PM	0.69
7/16/2015	5:00:00 PM	0.69
7/16/2015	5:15:00 PM	0.68
7/16/2015	5:30:00 PM	0.68
7/16/2015	5:45:00 PM	0.68
7/16/2015	6:00:00 PM	0.67
7/16/2015	6:15:00 PM	0.67
7/16/2015	6:30:00 PM	0.67
7/16/2015	6:45:00 PM	0.67
7/16/2015	7:00:00 PM	0.67
7/16/2015	7:15:00 PM	0.67

Georges Ditch Return Gage

DATE	TIME	GAGE
7/16/2015	7:30:00 PM	0.67
7/16/2015	7:45:00 PM	0.67
7/16/2015	8:00:00 PM	0.67
7/16/2015	8:15:00 PM	0.67
7/16/2015	8:30:00 PM	0.67
7/16/2015	8:45:00 PM	0.67
7/16/2015	9:00:00 PM	0.67
7/16/2015	9:15:00 PM	0.67
7/16/2015	9:30:00 PM	0.67
7/16/2015	9:45:00 PM	0.67
7/16/2015	10:00:00 PM	0.67
7/16/2015	10:15:00 PM	0.67
7/16/2015	10:30:00 PM	0.67
7/16/2015	10:45:00 PM	0.67
7/16/2015	11:00:00 PM	0.67
7/16/2015	11:15:00 PM	0.67
7/16/2015	11:30:00 PM	0.67
7/16/2015	11:45:00 PM	0.67
7/17/2015	12:00:00 AM	0.67
7/17/2015	12:15:00 AM	0.67
7/17/2015	12:30:00 AM	0.67
7/17/2015	12:45:00 AM	0.67
7/17/2015	1:00:00 AM	0.67
7/17/2015	1:15:00 AM	0.67
7/17/2015	1:30:00 AM	0.67
7/17/2015	1:45:00 AM	0.67
7/17/2015	2:00:00 AM	0.67
7/17/2015	2:15:00 AM	0.67
7/17/2015	2:30:00 AM	0.67
7/17/2015	2:45:00 AM	0.67
7/17/2015	3:00:00 AM	0.67
7/17/2015	3:15:00 AM	0.67
7/17/2015	3:30:00 AM	0.67
7/17/2015	3:45:00 AM	0.67
7/17/2015	4:00:00 AM	0.67
7/17/2015	4:15:00 AM	0.67
7/17/2015	4:30:00 AM	0.67
7/17/2015	4:45:00 AM	0.67
7/17/2015	5:00:00 AM	0.67
7/17/2015	5:15:00 AM	0.67
7/17/2015	5:30:00 AM	0.67
7/17/2015	5:45:00 AM	0.67
7/17/2015	6:00:00 AM	0.67
7/17/2015	6:15:00 AM	0.67
7/17/2015	6:30:00 AM	0.67
7/17/2015	6:45:00 AM	0.67

Georges Ditch Return Gage

DATE	TIME	GAGE
7/17/2015	7:00:00 AM	0.67
7/17/2015	7:15:00 AM	0.67
7/17/2015	7:30:00 AM	0.67
7/17/2015	7:45:00 AM	0.67
7/17/2015	8:00:00 AM	0.67
7/17/2015	8:15:00 AM	0.67
7/17/2015	8:30:00 AM	0.67
7/17/2015	8:45:00 AM	0.67
7/17/2015	9:00:00 AM	0.67
7/17/2015	9:15:00 AM	0.67
7/17/2015	9:30:00 AM	0.67
7/17/2015	9:45:00 AM	0.67
7/17/2015	10:00:00 AM	0.67
7/17/2015	10:15:00 AM	0.67
7/17/2015	10:30:00 AM	0.67
7/17/2015	10:45:00 AM	0.67
7/17/2015	11:00:00 AM	0.67
7/17/2015	11:15:00 AM	0.67
7/17/2015	11:30:00 AM	0.69
7/17/2015	11:45:00 AM	0.69
7/17/2015	12:00:00 PM	0.68
7/17/2015	12:15:00 PM	0.67
7/17/2015	12:30:00 PM	0.66
7/17/2015	12:45:00 PM	0.66
7/17/2015	1:00:00 PM	0.66
7/17/2015	1:15:00 PM	0.66
7/17/2015	1:30:00 PM	0.66
7/17/2015	1:45:00 PM	0.66
7/17/2015	2:00:00 PM	0.66
7/17/2015	2:15:00 PM	0.65
7/17/2015	2:30:00 PM	0.65
7/17/2015	2:45:00 PM	0.65
7/17/2015	3:00:00 PM	0.65
7/17/2015	3:15:00 PM	0.65
7/17/2015	3:30:00 PM	0.64
7/17/2015	3:45:00 PM	0.64
7/17/2015	4:00:00 PM	0.64
7/17/2015	4:15:00 PM	0.64
7/17/2015	4:30:00 PM	0.64
7/17/2015	4:45:00 PM	0.63
7/17/2015	5:00:00 PM	0.63
7/17/2015	5:15:00 PM	0.63
7/17/2015	5:30:00 PM	0.62
7/17/2015	5:45:00 PM	0.62
7/17/2015	6:00:00 PM	0.62
7/17/2015	6:15:00 PM	0.61

Georges Ditch Return Gage

DATE	TIME	GAGE
7/17/2015	6:30:00 PM	0.61
7/17/2015	6:45:00 PM	0.61
7/17/2015	7:00:00 PM	0.61
7/17/2015	7:15:00 PM	0.6
7/17/2015	7:30:00 PM	0.6
7/17/2015	7:45:00 PM	0.6
7/17/2015	8:00:00 PM	0.6
7/17/2015	8:15:00 PM	0.6
7/17/2015	8:30:00 PM	0.59
7/17/2015	8:45:00 PM	0.59
7/17/2015	9:00:00 PM	0.59
7/17/2015	9:15:00 PM	0.59
7/17/2015	9:30:00 PM	0.59
7/17/2015	9:45:00 PM	0.59
7/17/2015	10:00:00 PM	0.59
7/17/2015	10:15:00 PM	0.59
7/17/2015	10:30:00 PM	0.59
7/17/2015	10:45:00 PM	0.59
7/17/2015	11:00:00 PM	0.59
7/17/2015	11:15:00 PM	0.59
7/17/2015	11:30:00 PM	0.59
7/17/2015	11:45:00 PM	0.6
7/18/2015	12:00:00 AM	0.6
7/18/2015	12:15:00 AM	0.6
7/18/2015	12:30:00 AM	0.6
7/18/2015	12:45:00 AM	0.6
7/18/2015	1:00:00 AM	0.6
7/18/2015	1:15:00 AM	0.6
7/18/2015	1:30:00 AM	0.6
7/18/2015	1:45:00 AM	0.6
7/18/2015	2:00:00 AM	0.6
7/18/2015	2:15:00 AM	0.6
7/18/2015	2:30:00 AM	0.6
7/18/2015	2:45:00 AM	0.6
7/18/2015	3:00:00 AM	0.6
7/18/2015	3:15:00 AM	0.6
7/18/2015	3:30:00 AM	0.6
7/18/2015	3:45:00 AM	0.6
7/18/2015	4:00:00 AM	0.6
7/18/2015	4:15:00 AM	0.6
7/18/2015	4:30:00 AM	0.6
7/18/2015	4:45:00 AM	0.6
7/18/2015	5:00:00 AM	0.6
7/18/2015	5:15:00 AM	0.6
7/18/2015	5:30:00 AM	0.6
7/18/2015	5:45:00 AM	0.6

Georges Ditch Return Gage

DATE	TIME	GAGE
7/18/2015	6:00:00 AM	0.6
7/18/2015	6:15:00 AM	0.6
7/18/2015	6:30:00 AM	0.6
7/18/2015	6:45:00 AM	0.6
7/18/2015	7:00:00 AM	0.6
7/18/2015	7:15:00 AM	0.6
7/18/2015	7:30:00 AM	0.6
7/18/2015	7:45:00 AM	0.6
7/18/2015	8:00:00 AM	0.6
7/18/2015	8:15:00 AM	0.59
7/18/2015	8:30:00 AM	0.59
7/18/2015	8:45:00 AM	0.59
7/18/2015	9:00:00 AM	0.59
7/18/2015	9:15:00 AM	0.59
7/18/2015	9:30:00 AM	0.59
7/18/2015	9:45:00 AM	0.59
7/18/2015	10:00:00 AM	0.59
7/18/2015	10:15:00 AM	0.59
7/18/2015	10:30:00 AM	0.59
7/18/2015	10:45:00 AM	0.59
7/18/2015	11:00:00 AM	0.59
7/18/2015	11:15:00 AM	0.59
7/18/2015	11:30:00 AM	0.59
7/18/2015	11:45:00 AM	0.59
7/18/2015	12:00:00 PM	0.59
7/18/2015	12:15:00 PM	0.58
7/18/2015	12:30:00 PM	0.58
7/18/2015	12:45:00 PM	0.58
7/18/2015	1:00:00 PM	0.58
7/18/2015	1:15:00 PM	0.58
7/18/2015	1:30:00 PM	0.58
7/18/2015	1:45:00 PM	0.57
7/18/2015	2:00:00 PM	0.57
7/18/2015	2:15:00 PM	0.57
7/18/2015	2:30:00 PM	0.57
7/18/2015	2:45:00 PM	0.57
7/18/2015	3:00:00 PM	0.57
7/18/2015	3:15:00 PM	0.57
7/18/2015	3:30:00 PM	0.57
7/18/2015	3:45:00 PM	0.57
7/18/2015	4:00:00 PM	0.56
7/18/2015	4:15:00 PM	0.56
7/18/2015	4:30:00 PM	0.55
7/18/2015	4:45:00 PM	0.55
7/18/2015	5:00:00 PM	0.54
7/18/2015	5:15:00 PM	0.53

Georges Ditch Return Gage

DATE	TIME	GAGE
7/18/2015	5:30:00 PM	0.53
7/18/2015	5:45:00 PM	0.52
7/18/2015	6:00:00 PM	0.51
7/18/2015	6:15:00 PM	0.51
7/18/2015	6:30:00 PM	0.5
7/18/2015	6:45:00 PM	0.5
7/18/2015	7:00:00 PM	0.5
7/18/2015	7:15:00 PM	0.49
7/18/2015	7:30:00 PM	0.49
7/18/2015	7:45:00 PM	0.49
7/18/2015	8:00:00 PM	0.49
7/18/2015	8:15:00 PM	0.49
7/18/2015	8:30:00 PM	0.49
7/18/2015	8:45:00 PM	0.49
7/18/2015	9:00:00 PM	0.49
7/18/2015	9:15:00 PM	0.5
7/18/2015	9:30:00 PM	0.5
7/18/2015	9:45:00 PM	0.5
7/18/2015	10:00:00 PM	0.5
7/18/2015	10:15:00 PM	0.51
7/18/2015	10:30:00 PM	0.51
7/18/2015	10:45:00 PM	0.51
7/18/2015	11:00:00 PM	0.51
7/18/2015	11:15:00 PM	0.51
7/18/2015	11:30:00 PM	0.52
7/18/2015	11:45:00 PM	0.52
7/19/2015	12:00:00 AM	0.53
7/19/2015	12:15:00 AM	0.53
7/19/2015	12:30:00 AM	0.53
7/19/2015	12:45:00 AM	0.54
7/19/2015	1:00:00 AM	0.54
7/19/2015	1:15:00 AM	0.55
7/19/2015	1:30:00 AM	0.55
7/19/2015	1:45:00 AM	0.55
7/19/2015	2:00:00 AM	0.55
7/19/2015	2:15:00 AM	0.55
7/19/2015	2:30:00 AM	0.56
7/19/2015	2:45:00 AM	0.56
7/19/2015	3:00:00 AM	0.56
7/19/2015	3:15:00 AM	0.56
7/19/2015	3:30:00 AM	0.56
7/19/2015	3:45:00 AM	0.57
7/19/2015	4:00:00 AM	0.57
7/19/2015	4:15:00 AM	0.57
7/19/2015	4:30:00 AM	0.57
7/19/2015	4:45:00 AM	0.57

Georges Ditch Return Gage

DATE	TIME	GAGE
7/19/2015	5:00:00 AM	0.57
7/19/2015	5:15:00 AM	0.57
7/19/2015	5:30:00 AM	0.57
7/19/2015	5:45:00 AM	0.57
7/19/2015	6:00:00 AM	0.57
7/19/2015	6:15:00 AM	0.57
7/19/2015	6:30:00 AM	0.57
7/19/2015	6:45:00 AM	0.57
7/19/2015	7:00:00 AM	0.57
7/19/2015	7:15:00 AM	0.57
7/19/2015	7:30:00 AM	0.57
7/19/2015	7:45:00 AM	0.57
7/19/2015	8:00:00 AM	0.57
7/19/2015	8:15:00 AM	0.57
7/19/2015	8:30:00 AM	0.57
7/19/2015	8:45:00 AM	0.57
7/19/2015	9:00:00 AM	0.57
7/19/2015	9:15:00 AM	0.57
7/19/2015	9:30:00 AM	0.57
7/19/2015	9:45:00 AM	0.57
7/19/2015	10:00:00 AM	0.57
7/19/2015	10:15:00 AM	0.57
7/19/2015	10:30:00 AM	0.57
7/19/2015	10:45:00 AM	0.57
7/19/2015	11:00:00 AM	0.56
7/19/2015	11:15:00 AM	0.56
7/19/2015	11:30:00 AM	0.56
7/19/2015	11:45:00 AM	0.56
7/19/2015	12:00:00 PM	0.56
7/19/2015	12:15:00 PM	0.56
7/19/2015	12:30:00 PM	0.56
7/19/2015	12:45:00 PM	0.56
7/19/2015	1:00:00 PM	0.56
7/19/2015	1:15:00 PM	0.56
7/19/2015	1:30:00 PM	0.56
7/19/2015	1:45:00 PM	0.56
7/19/2015	2:00:00 PM	0.55
7/19/2015	2:15:00 PM	0.55
7/19/2015	2:30:00 PM	0.55
7/19/2015	2:45:00 PM	0.55
7/19/2015	3:00:00 PM	0.55
7/19/2015	3:15:00 PM	0.55
7/19/2015	3:30:00 PM	0.55
7/19/2015	3:45:00 PM	0.55
7/19/2015	4:00:00 PM	0.55
7/19/2015	4:15:00 PM	0.57

Georges Ditch Return Gage

DATE	TIME	GAGE
7/19/2015	4:30:00 PM	0.57
7/19/2015	4:45:00 PM	0.57
7/19/2015	5:00:00 PM	0.56
7/19/2015	5:15:00 PM	0.55
7/19/2015	5:30:00 PM	0.54
7/19/2015	5:45:00 PM	0.53
7/19/2015	6:00:00 PM	0.52
7/19/2015	6:15:00 PM	0.52
7/19/2015	6:30:00 PM	0.52
7/19/2015	6:45:00 PM	0.52
7/19/2015	7:00:00 PM	0.52
7/19/2015	7:15:00 PM	0.52
7/19/2015	7:30:00 PM	0.52
7/19/2015	7:45:00 PM	0.52
7/19/2015	8:00:00 PM	0.52
7/19/2015	8:15:00 PM	0.52
7/19/2015	8:30:00 PM	0.52
7/19/2015	8:45:00 PM	0.52
7/19/2015	9:00:00 PM	0.52
7/19/2015	9:15:00 PM	0.52
7/19/2015	9:30:00 PM	0.52
7/19/2015	9:45:00 PM	0.52
7/19/2015	10:00:00 PM	0.53
7/19/2015	10:15:00 PM	0.53
7/19/2015	10:30:00 PM	0.53
7/19/2015	10:45:00 PM	0.53
7/19/2015	11:00:00 PM	0.54
7/19/2015	11:15:00 PM	0.54
7/19/2015	11:30:00 PM	0.54
7/19/2015	11:45:00 PM	0.54
7/20/2015	12:00:00 AM	0.55
7/20/2015	12:15:00 AM	0.56
7/20/2015	12:30:00 AM	0.57
7/20/2015	12:45:00 AM	0.64
7/20/2015	1:00:00 AM	0.69
7/20/2015	1:15:00 AM	0.69
7/20/2015	1:30:00 AM	0.71
7/20/2015	1:45:00 AM	0.73
7/20/2015	2:00:00 AM	0.76
7/20/2015	2:15:00 AM	0.8
7/20/2015	2:30:00 AM	0.81
7/20/2015	2:45:00 AM	0.78
7/20/2015	3:00:00 AM	0.75
7/20/2015	3:15:00 AM	0.72
7/20/2015	3:30:00 AM	0.69
7/20/2015	3:45:00 AM	0.68

Georges Ditch Return Gage

DATE	TIME	GAGE
7/20/2015	4:00:00 AM	0.67
7/20/2015	4:15:00 AM	0.66
7/20/2015	4:30:00 AM	0.66
7/20/2015	4:45:00 AM	0.66
7/20/2015	5:00:00 AM	0.66
7/20/2015	5:15:00 AM	0.66
7/20/2015	5:30:00 AM	0.67
7/20/2015	5:45:00 AM	0.67
7/20/2015	6:00:00 AM	0.68
7/20/2015	6:15:00 AM	0.69
7/20/2015	6:30:00 AM	0.69
7/20/2015	6:45:00 AM	0.69
7/20/2015	7:00:00 AM	0.7
7/20/2015	7:15:00 AM	0.7
7/20/2015	7:30:00 AM	0.7
7/20/2015	7:45:00 AM	0.7
7/20/2015	8:00:00 AM	0.7
7/20/2015	8:15:00 AM	0.7
7/20/2015	8:30:00 AM	0.7
7/20/2015	8:45:00 AM	0.71
7/20/2015	9:00:00 AM	0.71
7/20/2015	9:15:00 AM	0.7
7/20/2015	9:30:00 AM	0.7
7/20/2015	9:45:00 AM	0.7
7/20/2015	10:00:00 AM	0.7
7/20/2015	10:15:00 AM	0.7
7/20/2015	10:30:00 AM	0.69
7/20/2015	10:45:00 AM	0.69
7/20/2015	11:00:00 AM	0.69
7/20/2015	11:15:00 AM	0.69
7/20/2015	11:30:00 AM	0.69
7/20/2015	11:45:00 AM	0.69
7/20/2015	12:00:00 PM	0.68
7/20/2015	12:15:00 PM	0.68
7/20/2015	12:30:00 PM	0.68
7/20/2015	12:45:00 PM	0.67
7/20/2015	1:00:00 PM	0.67
7/20/2015	1:15:00 PM	0.67
7/20/2015	1:30:00 PM	0.67
7/20/2015	1:45:00 PM	0.67
7/20/2015	2:00:00 PM	0.66
7/20/2015	2:15:00 PM	0.66
7/20/2015	2:30:00 PM	0.66
7/20/2015	2:45:00 PM	0.65
7/20/2015	3:00:00 PM	0.65
7/20/2015	3:15:00 PM	0.65

Georges Ditch Return Gage

DATE	TIME	GAGE
7/20/2015	3:30:00 PM	0.65
7/20/2015	3:45:00 PM	0.65
7/20/2015	4:00:00 PM	0.65
7/20/2015	4:15:00 PM	0.64
7/20/2015	4:30:00 PM	0.63
7/20/2015	4:45:00 PM	0.63
7/20/2015	5:00:00 PM	0.63
7/20/2015	5:15:00 PM	0.62
7/20/2015	5:30:00 PM	0.62
7/20/2015	5:45:00 PM	0.61
7/20/2015	6:00:00 PM	0.61
7/20/2015	6:15:00 PM	0.6
7/20/2015	6:30:00 PM	0.59
7/20/2015	6:45:00 PM	0.58
7/20/2015	7:00:00 PM	0.58
7/20/2015	7:15:00 PM	0.57
7/20/2015	7:30:00 PM	0.55
7/20/2015	7:45:00 PM	0.55
7/20/2015	8:00:00 PM	0.54
7/20/2015	8:15:00 PM	0.53
7/20/2015	8:30:00 PM	0.53
7/20/2015	8:45:00 PM	0.52
7/20/2015	9:00:00 PM	0.52
7/20/2015	9:15:00 PM	0.52
7/20/2015	9:30:00 PM	0.52
7/20/2015	9:45:00 PM	0.52
7/20/2015	10:00:00 PM	0.52
7/20/2015	10:15:00 PM	0.52
7/20/2015	10:30:00 PM	0.52
7/20/2015	10:45:00 PM	0.52
7/20/2015	11:00:00 PM	0.52
7/20/2015	11:15:00 PM	0.52
7/20/2015	11:30:00 PM	0.52
7/20/2015	11:45:00 PM	0.52
7/21/2015	12:00:00 AM	0.52
7/21/2015	12:15:00 AM	0.52
7/21/2015	12:30:00 AM	0.52
7/21/2015	12:45:00 AM	0.52
7/21/2015	1:00:00 AM	0.52
7/21/2015	1:15:00 AM	0.53
7/21/2015	1:30:00 AM	0.53
7/21/2015	1:45:00 AM	0.53
7/21/2015	2:00:00 AM	0.53
7/21/2015	2:15:00 AM	0.53
7/21/2015	2:30:00 AM	0.53
7/21/2015	2:45:00 AM	0.53

Georges Ditch Return Gage

DATE	TIME	GAGE
7/21/2015	3:00:00 AM	0.53
7/21/2015	3:15:00 AM	0.53
7/21/2015	3:30:00 AM	0.53
7/21/2015	3:45:00 AM	0.53
7/21/2015	4:00:00 AM	0.53
7/21/2015	4:15:00 AM	0.53
7/21/2015	4:30:00 AM	0.53
7/21/2015	4:45:00 AM	0.53
7/21/2015	5:00:00 AM	0.53
7/21/2015	5:15:00 AM	0.53
7/21/2015	5:30:00 AM	0.53
7/21/2015	5:45:00 AM	0.53
7/21/2015	6:00:00 AM	0.53
7/21/2015	6:15:00 AM	0.53
7/21/2015	6:30:00 AM	0.53
7/21/2015	6:45:00 AM	0.53
7/21/2015	7:00:00 AM	0.53
7/21/2015	7:15:00 AM	0.53
7/21/2015	7:30:00 AM	0.53
7/21/2015	7:45:00 AM	0.53
7/21/2015	8:00:00 AM	0.53
7/21/2015	8:15:00 AM	0.53
7/21/2015	8:30:00 AM	0.53
7/21/2015	8:45:00 AM	0.52
7/21/2015	9:00:00 AM	0.52
7/21/2015	9:15:00 AM	0.52
7/21/2015	9:30:00 AM	0.52
7/21/2015	9:45:00 AM	0.52
7/21/2015	10:00:00 AM	0.52
7/21/2015	10:15:00 AM	0.52
7/21/2015	10:30:00 AM	0.51
7/21/2015	10:45:00 AM	0.51
7/21/2015	11:00:00 AM	0.51
7/21/2015	11:15:00 AM	0.51
7/21/2015	11:30:00 AM	0.51
7/21/2015	11:45:00 AM	0.51
7/21/2015	12:00:00 PM	0.51
7/21/2015	12:15:00 PM	0.51
7/21/2015	12:30:00 PM	0.51
7/21/2015	12:45:00 PM	0.51
7/21/2015	1:00:00 PM	0.5
7/21/2015	1:15:00 PM	0.5
7/21/2015	1:30:00 PM	0.5
7/21/2015	1:45:00 PM	0.5
7/21/2015	2:00:00 PM	0.5
7/21/2015	2:15:00 PM	0.5

Georges Ditch Return Gage

DATE	TIME	GAGE
7/21/2015	2:30:00 PM	0.49
7/21/2015	2:45:00 PM	0.49
7/21/2015	3:00:00 PM	0.48
7/21/2015	3:15:00 PM	0.48
7/21/2015	3:30:00 PM	0.47
7/21/2015	3:45:00 PM	0.46
7/21/2015	4:00:00 PM	0.45
7/21/2015	4:15:00 PM	0.44
7/21/2015	4:30:00 PM	0.44
7/21/2015	4:45:00 PM	0.43
7/21/2015	5:00:00 PM	0.42
7/21/2015	5:15:00 PM	0.42
7/21/2015	5:30:00 PM	0.41
7/21/2015	5:45:00 PM	0.41
7/21/2015	6:00:00 PM	0.41
7/21/2015	6:15:00 PM	0.41
7/21/2015	6:30:00 PM	0.4
7/21/2015	6:45:00 PM	0.4
7/21/2015	7:00:00 PM	0.4
7/21/2015	7:15:00 PM	0.39
7/21/2015	7:30:00 PM	0.39
7/21/2015	7:45:00 PM	0.39
7/21/2015	8:00:00 PM	0.39
7/21/2015	8:15:00 PM	0.39
7/21/2015	8:30:00 PM	0.39
7/21/2015	8:45:00 PM	0.38
7/21/2015	9:00:00 PM	0.38
7/21/2015	9:15:00 PM	0.38
7/21/2015	9:30:00 PM	0.37
7/21/2015	9:45:00 PM	0.37
7/21/2015	10:00:00 PM	0.37
7/21/2015	10:15:00 PM	0.37
7/21/2015	10:30:00 PM	0.36
7/21/2015	10:45:00 PM	0.36
7/21/2015	11:00:00 PM	0.36
7/21/2015	11:15:00 PM	0.36
7/21/2015	11:30:00 PM	0.35
7/21/2015	11:45:00 PM	0.35
7/22/2015	12:00:00 AM	0.35
7/22/2015	12:15:00 AM	0.34
7/22/2015	12:30:00 AM	0.34
7/22/2015	12:45:00 AM	0.33
7/22/2015	1:00:00 AM	0.33
7/22/2015	1:15:00 AM	0.32
7/22/2015	1:30:00 AM	0.32
7/22/2015	1:45:00 AM	0.31

Georges Ditch Return Gage

DATE	TIME	GAGE
7/22/2015	2:00:00 AM	0.31
7/22/2015	2:15:00 AM	0.31
7/22/2015	2:30:00 AM	0.3
7/22/2015	2:45:00 AM	0.3
7/22/2015	3:00:00 AM	0.3
7/22/2015	3:15:00 AM	0.29
7/22/2015	3:30:00 AM	0.29
7/22/2015	3:45:00 AM	0.28
7/22/2015	4:00:00 AM	0.28
7/22/2015	4:15:00 AM	0.27
7/22/2015	4:30:00 AM	0.27
7/22/2015	4:45:00 AM	0.26
7/22/2015	5:00:00 AM	0.26
7/22/2015	5:15:00 AM	0.25
7/22/2015	5:30:00 AM	0.25
7/22/2015	5:45:00 AM	0.24
7/22/2015	6:00:00 AM	0.24
7/22/2015	6:15:00 AM	0.23
7/22/2015	6:30:00 AM	0.23
7/22/2015	6:45:00 AM	0.23
7/22/2015	7:00:00 AM	0.23
7/22/2015	7:15:00 AM	0.22
7/22/2015	7:30:00 AM	0.22
7/22/2015	7:45:00 AM	0.21
7/22/2015	8:00:00 AM	0.21
7/22/2015	8:15:00 AM	0.21
7/22/2015	8:30:00 AM	0.2
7/22/2015	8:45:00 AM	0.2
7/22/2015	9:00:00 AM	0.19
7/22/2015	9:15:00 AM	0.19
7/22/2015	9:30:00 AM	0.19
7/22/2015	9:45:00 AM	0.18
7/22/2015	10:00:00 AM	0.18
7/22/2015	10:15:00 AM	0.17
7/22/2015	10:30:00 AM	0.17
7/22/2015	10:45:00 AM	0.17
7/22/2015	11:00:00 AM	0.16
7/22/2015	11:15:00 AM	0.16
7/22/2015	11:30:00 AM	0.16
7/22/2015	11:45:00 AM	0.15
7/22/2015	12:00:00 PM	0.15
7/22/2015	12:15:00 PM	0.15
7/22/2015	12:30:00 PM	0.14
7/22/2015	12:45:00 PM	0.14
7/22/2015	1:00:00 PM	0.14
7/22/2015	1:15:00 PM	0.14

Georges Ditch Return Gage

DATE	TIME	GAGE
7/22/2015	1:30:00 PM	0.13
7/22/2015	1:45:00 PM	0.13
7/22/2015	2:00:00 PM	0.13
7/22/2015	2:15:00 PM	0.13
7/22/2015	2:30:00 PM	0.12
7/22/2015	2:45:00 PM	0.12
7/22/2015	3:00:00 PM	0.12
7/22/2015	3:15:00 PM	0.11
7/22/2015	3:30:00 PM	0.11
7/22/2015	3:45:00 PM	0.11
7/22/2015	4:00:00 PM	0.1
7/22/2015	4:15:00 PM	0.1
7/22/2015	4:30:00 PM	0.1
7/22/2015	4:45:00 PM	0.09
7/22/2015	5:00:00 PM	0.09
7/22/2015	5:15:00 PM	0.09
7/22/2015	5:30:00 PM	0.09
7/22/2015	5:45:00 PM	0.09
7/22/2015	6:00:00 PM	0.08
7/22/2015	6:15:00 PM	0.08
7/22/2015	6:30:00 PM	0.08
7/22/2015	6:45:00 PM	0.08
7/22/2015	7:00:00 PM	0.08
7/22/2015	7:15:00 PM	0.07
7/22/2015	7:30:00 PM	0.07
7/22/2015	7:45:00 PM	0.07
7/22/2015	8:00:00 PM	0.07
7/22/2015	8:15:00 PM	0.07
7/22/2015	8:30:00 PM	0.07
7/22/2015	8:45:00 PM	0.07
7/22/2015	9:00:00 PM	0.07
7/22/2015	9:15:00 PM	0.06
7/22/2015	9:30:00 PM	0.06
7/22/2015	9:45:00 PM	0.06
7/22/2015	10:00:00 PM	0.06
7/22/2015	10:15:00 PM	0.06
7/22/2015	10:30:00 PM	0.06
7/22/2015	10:45:00 PM	0.06
7/22/2015	11:00:00 PM	0.06
7/22/2015	11:15:00 PM	0.05
7/22/2015	11:30:00 PM	0.05
7/22/2015	11:45:00 PM	0.05
7/23/2015	12:00:00 AM	0.05
7/23/2015	12:15:00 AM	0.05
7/23/2015	12:30:00 AM	0.05
7/23/2015	12:45:00 AM	0.05

Georges Ditch Return Gage

DATE	TIME	GAGE
7/23/2015	1:00:00 AM	0.05
7/23/2015	1:15:00 AM	0.05
7/23/2015	1:30:00 AM	0.05
7/23/2015	1:45:00 AM	0.05
7/23/2015	2:00:00 AM	0.05
7/23/2015	2:15:00 AM	0.05
7/23/2015	2:30:00 AM	0.05
7/23/2015	2:45:00 AM	0.05
7/23/2015	3:00:00 AM	0.05
7/23/2015	3:15:00 AM	0.05
7/23/2015	3:30:00 AM	0.05
7/23/2015	3:45:00 AM	0.05
7/23/2015	4:00:00 AM	0.04
7/23/2015	4:15:00 AM	0.04
7/23/2015	4:30:00 AM	0.04
7/23/2015	4:45:00 AM	0.04
7/23/2015	5:00:00 AM	0.04
7/23/2015	5:15:00 AM	0.04
7/23/2015	5:30:00 AM	0.04
7/23/2015	5:45:00 AM	0.04
7/23/2015	6:00:00 AM	0.04
7/23/2015	6:15:00 AM	0.04
7/23/2015	6:30:00 AM	0.04
7/23/2015	6:45:00 AM	0.04
7/23/2015	7:00:00 AM	0.04
7/23/2015	7:15:00 AM	0.04
7/23/2015	7:30:00 AM	0.04
7/23/2015	7:45:00 AM	0.04
7/23/2015	8:00:00 AM	0.03
7/23/2015	8:15:00 AM	0.03
7/23/2015	8:30:00 AM	0.03
7/23/2015	8:45:00 AM	0.03
7/23/2015	9:00:00 AM	0.03
7/23/2015	9:15:00 AM	0.03
7/23/2015	9:30:00 AM	0.03
7/23/2015	9:45:00 AM	0.03
7/23/2015	10:00:00 AM	0.03
7/23/2015	10:15:00 AM	0.03
7/23/2015	10:30:00 AM	0.03
7/23/2015	10:45:00 AM	0.03
7/23/2015	11:00:00 AM	0.03
7/23/2015	11:15:00 AM	0.03
7/23/2015	11:30:00 AM	0.03
7/23/2015	11:45:00 AM	0.03
7/23/2015	12:00:00 PM	0.03
7/23/2015	12:15:00 PM	0.03

Georges Ditch Return Gage

DATE	TIME	GAGE
7/23/2015	12:30:00 PM	0.03
7/23/2015	12:45:00 PM	0.03
7/23/2015	1:00:00 PM	0.02
7/23/2015	1:15:00 PM	0.02
7/23/2015	1:30:00 PM	0.02
7/23/2015	1:45:00 PM	0.02
7/23/2015	2:00:00 PM	0.02
7/23/2015	2:15:00 PM	0.02
7/23/2015	2:30:00 PM	0.02
7/23/2015	2:45:00 PM	0.02
7/23/2015	3:00:00 PM	0.02
7/23/2015	3:15:00 PM	0.02
7/23/2015	3:30:00 PM	0.02
7/23/2015	3:45:00 PM	0.02
7/23/2015	4:00:00 PM	0.02
7/23/2015	4:15:00 PM	0.02
7/23/2015	4:30:00 PM	0.02
7/23/2015	4:45:00 PM	0.01
7/23/2015	5:00:00 PM	0.01
7/23/2015	5:15:00 PM	0.01
7/23/2015	5:30:00 PM	0.01
7/23/2015	5:45:00 PM	0.01
7/23/2015	6:00:00 PM	0.01
7/23/2015	6:15:00 PM	0.01
7/23/2015	6:30:00 PM	0.01
7/23/2015	6:45:00 PM	0.01
7/23/2015	7:00:00 PM	0.01
7/23/2015	7:15:00 PM	0.01
7/23/2015	7:30:00 PM	0.01
7/23/2015	7:45:00 PM	0.01
7/23/2015	8:00:00 PM	0.01
7/23/2015	8:15:00 PM	0.01
7/23/2015	8:30:00 PM	0.01
7/23/2015	8:45:00 PM	0.01
7/23/2015	9:00:00 PM	0.01
7/23/2015	9:15:00 PM	0.01
7/23/2015	9:30:00 PM	0.01
7/23/2015	9:45:00 PM	0.01
7/23/2015	10:00:00 PM	0.01
7/23/2015	10:15:00 PM	0.01
7/23/2015	10:30:00 PM	0.01
7/23/2015	10:45:00 PM	0.01
7/23/2015	11:00:00 PM	0.01
7/23/2015	11:15:00 PM	0.01
7/23/2015	11:30:00 PM	0.01
7/23/2015	11:45:00 PM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
7/24/2015	12:00:00 AM	0.01
7/24/2015	12:15:00 AM	0.01
7/24/2015	12:30:00 AM	0.01
7/24/2015	12:45:00 AM	0.01
7/24/2015	1:00:00 AM	0.01
7/24/2015	1:15:00 AM	0.01
7/24/2015	1:30:00 AM	0.01
7/24/2015	1:45:00 AM	0.01
7/24/2015	2:00:00 AM	0.01
7/24/2015	2:15:00 AM	0.01
7/24/2015	2:30:00 AM	0.01
7/24/2015	2:45:00 AM	0.01
7/24/2015	3:00:00 AM	0.01
7/24/2015	3:15:00 AM	0.01
7/24/2015	3:30:00 AM	0.01
7/24/2015	3:45:00 AM	0.01
7/24/2015	4:00:00 AM	0.01
7/24/2015	4:15:00 AM	0.01
7/24/2015	4:30:00 AM	0.25
7/24/2015	4:45:00 AM	0.28
7/24/2015	5:00:00 AM	0.29
7/24/2015	5:15:00 AM	0.29
7/24/2015	5:30:00 AM	0.3
7/24/2015	5:45:00 AM	0.31
7/24/2015	6:00:00 AM	0.31
7/24/2015	6:15:00 AM	0.31
7/24/2015	6:30:00 AM	0.32
7/24/2015	6:45:00 AM	0.32
7/24/2015	7:00:00 AM	0.33
7/24/2015	7:15:00 AM	0.33
7/24/2015	7:30:00 AM	0.33
7/24/2015	7:45:00 AM	0.33
7/24/2015	8:00:00 AM	0.33
7/24/2015	8:15:00 AM	0.34
7/24/2015	8:30:00 AM	0.34
7/24/2015	8:45:00 AM	0.34
7/24/2015	9:00:00 AM	0.34
7/24/2015	9:15:00 AM	0.35
7/24/2015	9:30:00 AM	0.35
7/24/2015	9:45:00 AM	0.35
7/24/2015	10:00:00 AM	0.35
7/24/2015	10:15:00 AM	0.35
7/24/2015	10:30:00 AM	0.35
7/24/2015	10:45:00 AM	0.35
7/24/2015	11:00:00 AM	0.36
7/24/2015	11:15:00 AM	0.36

Georges Ditch Return Gage

DATE	TIME	GAGE
7/24/2015	11:30:00 AM	0.36
7/24/2015	11:45:00 AM	0.36
7/24/2015	12:00:00 PM	0.37
7/24/2015	12:15:00 PM	0.37
7/24/2015	12:30:00 PM	0.37
7/24/2015	12:45:00 PM	0.37
7/24/2015	1:00:00 PM	0.38
7/24/2015	1:15:00 PM	0.38
7/24/2015	1:30:00 PM	0.38
7/24/2015	1:45:00 PM	0.39
7/24/2015	2:00:00 PM	0.39
7/24/2015	2:15:00 PM	0.39
7/24/2015	2:30:00 PM	0.39
7/24/2015	2:45:00 PM	0.4
7/24/2015	3:00:00 PM	0.4
7/24/2015	3:15:00 PM	0.4
7/24/2015	3:30:00 PM	0.4
7/24/2015	3:45:00 PM	0.4
7/24/2015	4:00:00 PM	0.4
7/24/2015	4:15:00 PM	0.4
7/24/2015	4:30:00 PM	0.4
7/24/2015	4:45:00 PM	0.39
7/24/2015	5:00:00 PM	0.39
7/24/2015	5:15:00 PM	0.39
7/24/2015	5:30:00 PM	0.39
7/24/2015	5:45:00 PM	0.39
7/24/2015	6:00:00 PM	0.39
7/24/2015	6:15:00 PM	0.39
7/24/2015	6:30:00 PM	0.39
7/24/2015	6:45:00 PM	0.4
7/24/2015	7:00:00 PM	0.4
7/24/2015	7:15:00 PM	0.4
7/24/2015	7:30:00 PM	0.4
7/24/2015	7:45:00 PM	0.41
7/24/2015	8:00:00 PM	0.41
7/24/2015	8:15:00 PM	0.41
7/24/2015	8:30:00 PM	0.41
7/24/2015	8:45:00 PM	0.42
7/24/2015	9:00:00 PM	0.42
7/24/2015	9:15:00 PM	0.42
7/24/2015	9:30:00 PM	0.42
7/24/2015	9:45:00 PM	0.43
7/24/2015	10:00:00 PM	0.43
7/24/2015	10:15:00 PM	0.43
7/24/2015	10:30:00 PM	0.43
7/24/2015	10:45:00 PM	0.43

Georges Ditch Return Gage

DATE	TIME	GAGE
7/24/2015	11:00:00 PM	0.44
7/24/2015	11:15:00 PM	0.44
7/24/2015	11:30:00 PM	0.44
7/24/2015	11:45:00 PM	0.44
7/25/2015	12:00:00 AM	0.45
7/25/2015	12:15:00 AM	0.45
7/25/2015	12:30:00 AM	0.45
7/25/2015	12:45:00 AM	0.45
7/25/2015	1:00:00 AM	0.45
7/25/2015	1:15:00 AM	0.45
7/25/2015	1:30:00 AM	0.45
7/25/2015	1:45:00 AM	0.45
7/25/2015	2:00:00 AM	0.45
7/25/2015	2:15:00 AM	0.45
7/25/2015	2:30:00 AM	0.45
7/25/2015	2:45:00 AM	0.45
7/25/2015	3:00:00 AM	0.45
7/25/2015	3:15:00 AM	0.45
7/25/2015	3:30:00 AM	0.44
7/25/2015	3:45:00 AM	0.44
7/25/2015	4:00:00 AM	0.44
7/25/2015	4:15:00 AM	0.44
7/25/2015	4:30:00 AM	0.44
7/25/2015	4:45:00 AM	0.44
7/25/2015	5:00:00 AM	0.43
7/25/2015	5:15:00 AM	0.43
7/25/2015	5:30:00 AM	0.43
7/25/2015	5:45:00 AM	0.43
7/25/2015	6:00:00 AM	0.43
7/25/2015	6:15:00 AM	0.43
7/25/2015	6:30:00 AM	0.42
7/25/2015	6:45:00 AM	0.42
7/25/2015	7:00:00 AM	0.42
7/25/2015	7:15:00 AM	0.42
7/25/2015	7:30:00 AM	0.42
7/25/2015	7:45:00 AM	0.42
7/25/2015	8:00:00 AM	0.42
7/25/2015	8:15:00 AM	0.41
7/25/2015	8:30:00 AM	0.41
7/25/2015	8:45:00 AM	0.41
7/25/2015	9:00:00 AM	0.41
7/25/2015	9:15:00 AM	0.41
7/25/2015	9:30:00 AM	0.41
7/25/2015	9:45:00 AM	0.41
7/25/2015	10:00:00 AM	0.41
7/25/2015	10:15:00 AM	0.41

Georges Ditch Return Gage

DATE	TIME	GAGE
7/25/2015	10:30:00 AM	0.41
7/25/2015	10:45:00 AM	0.41
7/25/2015	11:00:00 AM	0.41
7/25/2015	11:15:00 AM	0.41
7/25/2015	11:30:00 AM	0.41
7/25/2015	11:45:00 AM	0.41
7/25/2015	12:00:00 PM	0.42
7/25/2015	12:15:00 PM	0.42
7/25/2015	12:30:00 PM	0.42
7/25/2015	12:45:00 PM	0.42
7/25/2015	1:00:00 PM	0.42
7/25/2015	1:15:00 PM	0.43
7/25/2015	1:30:00 PM	0.43
7/25/2015	1:45:00 PM	0.43
7/25/2015	2:00:00 PM	0.43
7/25/2015	2:15:00 PM	0.43
7/25/2015	2:30:00 PM	0.43
7/25/2015	2:45:00 PM	0.43
7/25/2015	3:00:00 PM	0.44
7/25/2015	3:15:00 PM	0.44
7/25/2015	3:30:00 PM	0.43
7/25/2015	3:45:00 PM	0.43
7/25/2015	4:00:00 PM	0.43
7/25/2015	4:15:00 PM	0.43
7/25/2015	4:30:00 PM	0.43
7/25/2015	4:45:00 PM	0.42
7/25/2015	5:00:00 PM	0.42
7/25/2015	5:15:00 PM	0.42
7/25/2015	5:30:00 PM	0.42
7/25/2015	5:45:00 PM	0.42
7/25/2015	6:00:00 PM	0.42
7/25/2015	6:15:00 PM	0.42
7/25/2015	6:30:00 PM	0.42
7/25/2015	6:45:00 PM	0.42
7/25/2015	7:00:00 PM	0.42
7/25/2015	7:15:00 PM	0.42
7/25/2015	7:30:00 PM	0.42
7/25/2015	7:45:00 PM	0.42
7/25/2015	8:00:00 PM	0.42
7/25/2015	8:15:00 PM	0.42
7/25/2015	8:30:00 PM	0.42
7/25/2015	8:45:00 PM	0.42
7/25/2015	9:00:00 PM	0.42
7/25/2015	9:15:00 PM	0.42
7/25/2015	9:30:00 PM	0.42
7/25/2015	9:45:00 PM	0.43

Georges Ditch Return Gage

DATE	TIME	GAGE
7/25/2015	10:00:00 PM	0.43
7/25/2015	10:15:00 PM	0.43
7/25/2015	10:30:00 PM	0.43
7/25/2015	10:45:00 PM	0.43
7/25/2015	11:00:00 PM	0.43
7/25/2015	11:15:00 PM	0.43
7/25/2015	11:30:00 PM	0.43
7/25/2015	11:45:00 PM	0.43
7/26/2015	12:00:00 AM	0.43
7/26/2015	12:15:00 AM	0.43
7/26/2015	12:30:00 AM	0.43
7/26/2015	12:45:00 AM	0.43
7/26/2015	1:00:00 AM	0.43
7/26/2015	1:15:00 AM	0.43
7/26/2015	1:30:00 AM	0.43
7/26/2015	1:45:00 AM	0.43
7/26/2015	2:00:00 AM	0.43
7/26/2015	2:15:00 AM	0.43
7/26/2015	2:30:00 AM	0.43
7/26/2015	2:45:00 AM	0.43
7/26/2015	3:00:00 AM	0.43
7/26/2015	3:15:00 AM	0.42
7/26/2015	3:30:00 AM	0.42
7/26/2015	3:45:00 AM	0.42
7/26/2015	4:00:00 AM	0.42
7/26/2015	4:15:00 AM	0.42
7/26/2015	4:30:00 AM	0.41
7/26/2015	4:45:00 AM	0.41
7/26/2015	5:00:00 AM	0.41
7/26/2015	5:15:00 AM	0.4
7/26/2015	5:30:00 AM	0.4
7/26/2015	5:45:00 AM	0.4
7/26/2015	6:00:00 AM	0.39
7/26/2015	6:15:00 AM	0.39
7/26/2015	6:30:00 AM	0.39
7/26/2015	6:45:00 AM	0.39
7/26/2015	7:00:00 AM	0.38
7/26/2015	7:15:00 AM	0.38
7/26/2015	7:30:00 AM	0.38
7/26/2015	7:45:00 AM	0.38
7/26/2015	8:00:00 AM	0.37
7/26/2015	8:15:00 AM	0.37
7/26/2015	8:30:00 AM	0.37
7/26/2015	8:45:00 AM	0.37
7/26/2015	9:00:00 AM	0.36
7/26/2015	9:15:00 AM	0.36

Georges Ditch Return Gage

DATE	TIME	GAGE
7/26/2015	9:30:00 AM	0.36
7/26/2015	9:45:00 AM	0.35
7/26/2015	10:00:00 AM	0.35
7/26/2015	10:15:00 AM	0.35
7/26/2015	10:30:00 AM	0.35
7/26/2015	10:45:00 AM	0.35
7/26/2015	11:00:00 AM	0.34
7/26/2015	11:15:00 AM	0.34
7/26/2015	11:30:00 AM	0.34
7/26/2015	11:45:00 AM	0.34
7/26/2015	12:00:00 PM	0.34
7/26/2015	12:15:00 PM	0.34
7/26/2015	12:30:00 PM	0.33
7/26/2015	12:45:00 PM	0.33
7/26/2015	1:00:00 PM	0.33
7/26/2015	1:15:00 PM	0.33
7/26/2015	1:30:00 PM	0.33
7/26/2015	1:45:00 PM	0.33
7/26/2015	2:00:00 PM	0.33
7/26/2015	2:15:00 PM	0.33
7/26/2015	2:30:00 PM	0.33
7/26/2015	2:45:00 PM	0.32
7/26/2015	3:00:00 PM	0.32
7/26/2015	3:15:00 PM	0.32
7/26/2015	3:30:00 PM	0.32
7/26/2015	3:45:00 PM	0.32
7/26/2015	4:00:00 PM	0.31
7/26/2015	4:15:00 PM	0.31
7/26/2015	4:30:00 PM	0.31
7/26/2015	4:45:00 PM	0.3
7/26/2015	5:00:00 PM	0.3
7/26/2015	5:15:00 PM	0.3
7/26/2015	5:30:00 PM	0.3
7/26/2015	5:45:00 PM	0.29
7/26/2015	6:00:00 PM	0.29
7/26/2015	6:15:00 PM	0.29
7/26/2015	6:30:00 PM	0.29
7/26/2015	6:45:00 PM	0.29
7/26/2015	7:00:00 PM	0.29
7/26/2015	7:15:00 PM	0.29
7/26/2015	7:30:00 PM	0.29
7/26/2015	7:45:00 PM	0.29
7/26/2015	8:00:00 PM	0.29
7/26/2015	8:15:00 PM	0.29
7/26/2015	8:30:00 PM	0.29
7/26/2015	8:45:00 PM	0.29

Georges Ditch Return Gage

DATE	TIME	GAGE
7/26/2015	9:00:00 PM	0.3
7/26/2015	9:15:00 PM	0.3
7/26/2015	9:30:00 PM	0.3
7/26/2015	9:45:00 PM	0.31
7/26/2015	10:00:00 PM	0.31
7/26/2015	10:15:00 PM	0.31
7/26/2015	10:30:00 PM	0.31
7/26/2015	10:45:00 PM	0.31
7/26/2015	11:00:00 PM	0.32
7/26/2015	11:15:00 PM	0.32
7/26/2015	11:30:00 PM	0.32
7/26/2015	11:45:00 PM	0.33
7/27/2015	12:00:00 AM	0.33
7/27/2015	12:15:00 AM	0.33
7/27/2015	12:30:00 AM	0.33
7/27/2015	12:45:00 AM	0.33
7/27/2015	1:00:00 AM	0.33
7/27/2015	1:15:00 AM	0.34
7/27/2015	1:30:00 AM	0.34
7/27/2015	1:45:00 AM	0.34
7/27/2015	2:00:00 AM	0.34
7/27/2015	2:15:00 AM	0.34
7/27/2015	2:30:00 AM	0.34
7/27/2015	2:45:00 AM	0.34
7/27/2015	3:00:00 AM	0.34
7/27/2015	3:15:00 AM	0.34
7/27/2015	3:30:00 AM	0.34
7/27/2015	3:45:00 AM	0.34
7/27/2015	4:00:00 AM	0.34
7/27/2015	4:15:00 AM	0.34
7/27/2015	4:30:00 AM	0.34
7/27/2015	4:45:00 AM	0.34
7/27/2015	5:00:00 AM	0.34
7/27/2015	5:15:00 AM	0.34
7/27/2015	5:30:00 AM	0.34
7/27/2015	5:45:00 AM	0.34
7/27/2015	6:00:00 AM	0.33
7/27/2015	6:15:00 AM	0.33
7/27/2015	6:30:00 AM	0.33
7/27/2015	6:45:00 AM	0.33
7/27/2015	7:00:00 AM	0.33
7/27/2015	7:15:00 AM	0.33
7/27/2015	7:30:00 AM	0.33
7/27/2015	7:45:00 AM	0.33
7/27/2015	8:00:00 AM	0.33
7/27/2015	8:15:00 AM	0.33

Georges Ditch Return Gage

DATE	TIME	GAGE
7/27/2015	8:30:00 AM	0.33
7/27/2015	8:45:00 AM	0.32
7/27/2015	9:00:00 AM	0.32
7/27/2015	9:15:00 AM	0.32
7/27/2015	9:30:00 AM	0.32
7/27/2015	9:45:00 AM	0.32
7/27/2015	10:00:00 AM	0.32
7/27/2015	10:15:00 AM	0.32
7/27/2015	10:30:00 AM	0.32
7/27/2015	10:45:00 AM	0.32
7/27/2015	11:00:00 AM	0.32
7/27/2015	11:15:00 AM	0.32
7/27/2015	11:30:00 AM	0.33
7/27/2015	11:45:00 AM	0.33
7/27/2015	12:00:00 PM	0.33
7/27/2015	12:15:00 PM	0.33
7/27/2015	12:30:00 PM	0.34
7/27/2015	12:45:00 PM	0.34
7/27/2015	1:00:00 PM	0.34
7/27/2015	1:15:00 PM	0.34
7/27/2015	1:30:00 PM	0.35
7/27/2015	1:45:00 PM	0.35
7/27/2015	2:00:00 PM	0.35
7/27/2015	2:15:00 PM	0.35
7/27/2015	2:30:00 PM	0.36
7/27/2015	2:45:00 PM	0.36
7/27/2015	3:00:00 PM	0.36
7/27/2015	3:15:00 PM	0.36
7/27/2015	3:30:00 PM	0.36
7/27/2015	3:45:00 PM	0.37
7/27/2015	4:00:00 PM	0.37
7/27/2015	4:15:00 PM	0.37
7/27/2015	4:30:00 PM	0.37
7/27/2015	4:45:00 PM	0.37
7/27/2015	5:00:00 PM	0.37
7/27/2015	5:15:00 PM	0.37
7/27/2015	5:30:00 PM	0.37
7/27/2015	5:45:00 PM	0.37
7/27/2015	6:00:00 PM	0.37
7/27/2015	6:15:00 PM	0.37
7/27/2015	6:30:00 PM	0.37
7/27/2015	6:45:00 PM	0.37
7/27/2015	7:00:00 PM	0.37
7/27/2015	7:15:00 PM	0.37
7/27/2015	7:30:00 PM	0.37
7/27/2015	7:45:00 PM	0.37

Georges Ditch Return Gage

DATE	TIME	GAGE
7/27/2015	8:00:00 PM	0.37
7/27/2015	8:15:00 PM	0.37
7/27/2015	8:30:00 PM	0.37
7/27/2015	8:45:00 PM	0.37
7/27/2015	9:00:00 PM	0.37
7/27/2015	9:15:00 PM	0.37
7/27/2015	9:30:00 PM	0.37
7/27/2015	9:45:00 PM	0.37
7/27/2015	10:00:00 PM	0.37
7/27/2015	10:15:00 PM	0.37
7/27/2015	10:30:00 PM	0.37
7/27/2015	10:45:00 PM	0.37
7/27/2015	11:00:00 PM	0.37
7/27/2015	11:15:00 PM	0.37
7/27/2015	11:30:00 PM	0.37
7/27/2015	11:45:00 PM	0.37
7/28/2015	12:00:00 AM	0.37
7/28/2015	12:15:00 AM	0.37
7/28/2015	12:30:00 AM	0.36
7/28/2015	12:45:00 AM	0.36
7/28/2015	1:00:00 AM	0.36
7/28/2015	1:15:00 AM	0.36
7/28/2015	1:30:00 AM	0.36
7/28/2015	1:45:00 AM	0.36
7/28/2015	2:00:00 AM	0.36
7/28/2015	2:15:00 AM	0.36
7/28/2015	2:30:00 AM	0.35
7/28/2015	2:45:00 AM	0.35
7/28/2015	3:00:00 AM	0.35
7/28/2015	3:15:00 AM	0.35
7/28/2015	3:30:00 AM	0.35
7/28/2015	3:45:00 AM	0.35
7/28/2015	4:00:00 AM	0.35
7/28/2015	4:15:00 AM	0.34
7/28/2015	4:30:00 AM	0.34
7/28/2015	4:45:00 AM	0.33
7/28/2015	5:00:00 AM	0.33
7/28/2015	5:15:00 AM	0.33
7/28/2015	5:30:00 AM	0.33
7/28/2015	5:45:00 AM	0.32
7/28/2015	6:00:00 AM	0.32
7/28/2015	6:15:00 AM	0.32
7/28/2015	6:30:00 AM	0.31
7/28/2015	6:45:00 AM	0.31
7/28/2015	7:00:00 AM	0.31
7/28/2015	7:15:00 AM	0.3

Georges Ditch Return Gage

DATE	TIME	GAGE
7/28/2015	7:30:00 AM	0.3
7/28/2015	7:45:00 AM	0.29
7/28/2015	8:00:00 AM	0.29
7/28/2015	8:15:00 AM	0.29
7/28/2015	8:30:00 AM	0.28
7/28/2015	8:45:00 AM	0.28
7/28/2015	9:00:00 AM	0.27
7/28/2015	9:15:00 AM	0.27
7/28/2015	9:30:00 AM	0.26
7/28/2015	9:45:00 AM	0.26
7/28/2015	10:00:00 AM	0.25
7/28/2015	10:15:00 AM	0.25
7/28/2015	10:30:00 AM	0.24
7/28/2015	10:45:00 AM	0.24
7/28/2015	11:00:00 AM	0.23
7/28/2015	11:15:00 AM	0.23
7/28/2015	11:30:00 AM	0.23
7/28/2015	11:45:00 AM	0.22
7/28/2015	12:00:00 PM	0.22
7/28/2015	12:15:00 PM	0.22
7/28/2015	12:30:00 PM	0.21
7/28/2015	12:45:00 PM	0.21
7/28/2015	1:00:00 PM	0.21
7/28/2015	1:15:00 PM	0.21
7/28/2015	1:30:00 PM	0.21
7/28/2015	1:45:00 PM	0.2
7/28/2015	2:00:00 PM	0.2
7/28/2015	2:15:00 PM	0.19
7/28/2015	2:30:00 PM	0.19
7/28/2015	2:45:00 PM	0.19
7/28/2015	3:00:00 PM	0.18
7/28/2015	3:15:00 PM	0.18
7/28/2015	3:30:00 PM	0.18
7/28/2015	3:45:00 PM	0.17
7/28/2015	4:00:00 PM	0.17
7/28/2015	4:15:00 PM	0.17
7/28/2015	4:30:00 PM	0.16
7/28/2015	4:45:00 PM	0.16
7/28/2015	5:00:00 PM	0.16
7/28/2015	5:15:00 PM	0.15
7/28/2015	5:30:00 PM	0.15
7/28/2015	5:45:00 PM	0.15
7/28/2015	6:00:00 PM	0.14
7/28/2015	6:15:00 PM	0.14
7/28/2015	6:30:00 PM	0.14
7/28/2015	6:45:00 PM	0.14

Georges Ditch Return Gage

DATE	TIME	GAGE
7/28/2015	7:00:00 PM	0.13
7/28/2015	7:15:00 PM	0.13
7/28/2015	7:30:00 PM	0.13
7/28/2015	7:45:00 PM	0.13
7/28/2015	8:00:00 PM	0.12
7/28/2015	8:15:00 PM	0.12
7/28/2015	8:30:00 PM	0.12
7/28/2015	8:45:00 PM	0.12
7/28/2015	9:00:00 PM	0.11
7/28/2015	9:15:00 PM	0.11
7/28/2015	9:30:00 PM	0.11
7/28/2015	9:45:00 PM	0.11
7/28/2015	10:00:00 PM	0.11
7/28/2015	10:15:00 PM	0.11
7/28/2015	10:30:00 PM	0.11
7/28/2015	10:45:00 PM	0.11
7/28/2015	11:00:00 PM	0.11
7/28/2015	11:15:00 PM	0.1
7/28/2015	11:30:00 PM	0.1
7/28/2015	11:45:00 PM	0.1
7/29/2015	12:00:00 AM	0.1
7/29/2015	12:15:00 AM	0.1
7/29/2015	12:30:00 AM	0.1
7/29/2015	12:45:00 AM	0.1
7/29/2015	1:00:00 AM	0.1
7/29/2015	1:15:00 AM	0.09
7/29/2015	1:30:00 AM	0.09
7/29/2015	1:45:00 AM	0.09
7/29/2015	2:00:00 AM	0.09
7/29/2015	2:15:00 AM	0.09
7/29/2015	2:30:00 AM	0.09
7/29/2015	2:45:00 AM	0.09
7/29/2015	3:00:00 AM	0.09
7/29/2015	3:15:00 AM	0.09
7/29/2015	3:30:00 AM	0.09
7/29/2015	3:45:00 AM	0.09
7/29/2015	4:00:00 AM	0.09
7/29/2015	4:15:00 AM	0.08
7/29/2015	4:30:00 AM	0.08
7/29/2015	4:45:00 AM	0.08
7/29/2015	5:00:00 AM	0.08
7/29/2015	5:15:00 AM	0.08
7/29/2015	5:30:00 AM	0.08
7/29/2015	5:45:00 AM	0.08
7/29/2015	6:00:00 AM	0.08
7/29/2015	6:15:00 AM	0.08

Georges Ditch Return Gage

DATE	TIME	GAGE
7/29/2015	6:30:00 AM	0.07
7/29/2015	6:45:00 AM	0.07
7/29/2015	7:00:00 AM	0.07
7/29/2015	7:15:00 AM	0.07
7/29/2015	7:30:00 AM	0.07
7/29/2015	7:45:00 AM	0.07
7/29/2015	8:00:00 AM	0.07
7/29/2015	8:15:00 AM	0.07
7/29/2015	8:30:00 AM	0.07
7/29/2015	8:45:00 AM	0.06
7/29/2015	9:00:00 AM	0.06
7/29/2015	9:15:00 AM	0.06
7/29/2015	9:30:00 AM	0.06
7/29/2015	9:45:00 AM	0.06
7/29/2015	10:00:00 AM	0.06
7/29/2015	10:15:00 AM	0.06
7/29/2015	10:30:00 AM	0.06
7/29/2015	10:45:00 AM	0.05
7/29/2015	11:00:00 AM	0.05
7/29/2015	11:15:00 AM	0.05
7/29/2015	11:30:00 AM	0.05
7/29/2015	11:45:00 AM	0.05
7/29/2015	12:00:00 PM	0.05
7/29/2015	12:15:00 PM	0.04
7/29/2015	12:30:00 PM	0.04
7/29/2015	12:45:00 PM	0.04
7/29/2015	1:00:00 PM	0.03
7/29/2015	1:15:00 PM	0.03
7/29/2015	1:30:00 PM	0.02
7/29/2015	1:45:00 PM	0.02
7/29/2015	2:00:00 PM	0.02
7/29/2015	2:15:00 PM	0.02
7/29/2015	2:30:00 PM	0.02
7/29/2015	2:45:00 PM	0.02
7/29/2015	3:00:00 PM	0.02
7/29/2015	3:15:00 PM	0.02
7/29/2015	3:30:00 PM	0.02
7/29/2015	3:45:00 PM	0.02
7/29/2015	4:00:00 PM	0.02
7/29/2015	4:15:00 PM	0.02
7/29/2015	4:30:00 PM	0.01
7/29/2015	4:45:00 PM	0.01
7/29/2015	5:00:00 PM	0.01
7/29/2015	5:15:00 PM	0.01
7/29/2015	5:30:00 PM	0.01
7/29/2015	5:45:00 PM	0.01

Georges Ditch Return Gage

DATE	TIME	GAGE
7/29/2015	6:00:00 PM	0.01
7/29/2015	6:15:00 PM	0.01
7/29/2015	6:30:00 PM	0.01
7/29/2015	6:45:00 PM	0.01
7/29/2015	7:00:00 PM	0.01
7/29/2015	7:15:00 PM	0.01
7/29/2015	7:30:00 PM	0.01
7/29/2015	7:45:00 PM	0.01
7/29/2015	8:00:00 PM	0.01
7/29/2015	8:15:00 PM	0.01
7/29/2015	8:30:00 PM	0.01
7/29/2015	8:45:00 PM	0.01
7/29/2015	9:00:00 PM	0
7/29/2015	9:15:00 PM	0
7/29/2015	9:30:00 PM	0
7/29/2015	9:45:00 PM	0
7/29/2015	10:00:00 PM	0
7/29/2015	10:15:00 PM	0
7/29/2015	10:30:00 PM	0
7/29/2015	10:45:00 PM	0
7/29/2015	11:00:00 PM	0
7/29/2015	11:15:00 PM	0
7/29/2015	11:30:00 PM	0
7/29/2015	11:45:00 PM	0
7/30/2015	12:00:00 AM	0
7/30/2015	12:15:00 AM	0
7/30/2015	12:30:00 AM	0
7/30/2015	12:45:00 AM	0
7/30/2015	1:00:00 AM	0
7/30/2015	1:15:00 AM	0
7/30/2015	1:30:00 AM	0
7/30/2015	1:45:00 AM	0
7/30/2015	2:00:00 AM	0
7/30/2015	2:15:00 AM	0
7/30/2015	2:30:00 AM	0
7/30/2015	2:45:00 AM	0
7/30/2015	3:00:00 AM	0
7/30/2015	3:15:00 AM	0
7/30/2015	3:30:00 AM	0
7/30/2015	3:45:00 AM	0
7/30/2015	4:00:00 AM	0
7/30/2015	4:15:00 AM	0
7/30/2015	4:30:00 AM	0
7/30/2015	4:45:00 AM	0
7/30/2015	5:00:00 AM	0
7/30/2015	5:15:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/30/2015	5:30:00 AM	0
7/30/2015	5:45:00 AM	0
7/30/2015	6:00:00 AM	0
7/30/2015	6:15:00 AM	0
7/30/2015	6:30:00 AM	0
7/30/2015	6:45:00 AM	0
7/30/2015	7:00:00 AM	0
7/30/2015	7:15:00 AM	0
7/30/2015	7:30:00 AM	0
7/30/2015	7:45:00 AM	0
7/30/2015	8:00:00 AM	0
7/30/2015	8:15:00 AM	0
7/30/2015	8:30:00 AM	0
7/30/2015	8:45:00 AM	0
7/30/2015	9:00:00 AM	0
7/30/2015	9:15:00 AM	0
7/30/2015	9:30:00 AM	0
7/30/2015	9:45:00 AM	0
7/30/2015	10:00:00 AM	0
7/30/2015	10:15:00 AM	0
7/30/2015	10:30:00 AM	0
7/30/2015	10:45:00 AM	0
7/30/2015	11:00:00 AM	0
7/30/2015	11:15:00 AM	0
7/30/2015	11:30:00 AM	0
7/30/2015	11:45:00 AM	0
7/30/2015	12:00:00 PM	0
7/30/2015	12:15:00 PM	0
7/30/2015	12:30:00 PM	0
7/30/2015	12:45:00 PM	0
7/30/2015	1:00:00 PM	0
7/30/2015	1:15:00 PM	0
7/30/2015	1:30:00 PM	0
7/30/2015	1:45:00 PM	0
7/30/2015	2:00:00 PM	0
7/30/2015	2:15:00 PM	0
7/30/2015	2:30:00 PM	0
7/30/2015	2:45:00 PM	0
7/30/2015	3:00:00 PM	0
7/30/2015	3:15:00 PM	0
7/30/2015	3:30:00 PM	0
7/30/2015	3:45:00 PM	0
7/30/2015	4:00:00 PM	0
7/30/2015	4:15:00 PM	0
7/30/2015	4:30:00 PM	0
7/30/2015	4:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/30/2015	5:00:00 PM	0
7/30/2015	5:15:00 PM	0
7/30/2015	5:30:00 PM	0
7/30/2015	5:45:00 PM	0
7/30/2015	6:00:00 PM	0
7/30/2015	6:15:00 PM	0
7/30/2015	6:30:00 PM	0
7/30/2015	6:45:00 PM	0
7/30/2015	7:00:00 PM	0
7/30/2015	7:15:00 PM	0
7/30/2015	7:30:00 PM	0
7/30/2015	7:45:00 PM	0
7/30/2015	8:00:00 PM	0
7/30/2015	8:15:00 PM	0
7/30/2015	8:30:00 PM	0
7/30/2015	8:45:00 PM	0
7/30/2015	9:00:00 PM	0
7/30/2015	9:15:00 PM	0
7/30/2015	9:30:00 PM	0
7/30/2015	9:45:00 PM	0
7/30/2015	10:00:00 PM	0
7/30/2015	10:15:00 PM	0
7/30/2015	10:30:00 PM	0
7/30/2015	10:45:00 PM	0
7/30/2015	11:00:00 PM	0
7/30/2015	11:15:00 PM	0
7/30/2015	11:30:00 PM	0
7/30/2015	11:45:00 PM	0
7/31/2015	12:00:00 AM	0
7/31/2015	12:15:00 AM	0
7/31/2015	12:30:00 AM	0
7/31/2015	12:45:00 AM	0
7/31/2015	1:00:00 AM	0
7/31/2015	1:15:00 AM	0
7/31/2015	1:30:00 AM	0
7/31/2015	1:45:00 AM	0
7/31/2015	2:00:00 AM	0
7/31/2015	2:15:00 AM	0
7/31/2015	2:30:00 AM	0
7/31/2015	2:45:00 AM	0
7/31/2015	3:00:00 AM	0
7/31/2015	3:15:00 AM	0
7/31/2015	3:30:00 AM	0
7/31/2015	3:45:00 AM	0
7/31/2015	4:00:00 AM	0
7/31/2015	4:15:00 AM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/31/2015	4:30:00 AM	0
7/31/2015	4:45:00 AM	0
7/31/2015	5:00:00 AM	0
7/31/2015	5:15:00 AM	0
7/31/2015	5:30:00 AM	0
7/31/2015	5:45:00 AM	0
7/31/2015	6:00:00 AM	0
7/31/2015	6:15:00 AM	0
7/31/2015	6:30:00 AM	0
7/31/2015	6:45:00 AM	0
7/31/2015	7:00:00 AM	0
7/31/2015	7:15:00 AM	0
7/31/2015	7:30:00 AM	0
7/31/2015	7:45:00 AM	0
7/31/2015	8:00:00 AM	0
7/31/2015	8:15:00 AM	0
7/31/2015	8:30:00 AM	0
7/31/2015	8:45:00 AM	0
7/31/2015	9:00:00 AM	0
7/31/2015	9:15:00 AM	0
7/31/2015	9:30:00 AM	0
7/31/2015	9:45:00 AM	0
7/31/2015	10:00:00 AM	0
7/31/2015	10:15:00 AM	0
7/31/2015	10:30:00 AM	0
7/31/2015	10:45:00 AM	0
7/31/2015	11:00:00 AM	0
7/31/2015	11:15:00 AM	0
7/31/2015	11:30:00 AM	0
7/31/2015	11:45:00 AM	0
7/31/2015	12:00:00 PM	0
7/31/2015	12:15:00 PM	0
7/31/2015	12:30:00 PM	0
7/31/2015	12:45:00 PM	0
7/31/2015	1:00:00 PM	0
7/31/2015	1:15:00 PM	0
7/31/2015	1:30:00 PM	0
7/31/2015	1:45:00 PM	0
7/31/2015	2:00:00 PM	0
7/31/2015	2:15:00 PM	0
7/31/2015	2:30:00 PM	0
7/31/2015	2:45:00 PM	0
7/31/2015	3:00:00 PM	0
7/31/2015	3:15:00 PM	0
7/31/2015	3:30:00 PM	0
7/31/2015	3:45:00 PM	0

Georges Ditch Return Gage

DATE	TIME	GAGE
7/31/2015	4:00:00 PM	0
7/31/2015	4:15:00 PM	0
7/31/2015	4:30:00 PM	0
7/31/2015	4:45:00 PM	0
7/31/2015	5:00:00 PM	0
7/31/2015	5:15:00 PM	0
7/31/2015	5:30:00 PM	0
7/31/2015	5:45:00 PM	0
7/31/2015	6:00:00 PM	0
7/31/2015	6:15:00 PM	0
7/31/2015	6:30:00 PM	0
7/31/2015	6:45:00 PM	0
7/31/2015	7:00:00 PM	0
7/31/2015	7:15:00 PM	0
7/31/2015	7:30:00 PM	0
7/31/2015	7:45:00 PM	0
7/31/2015	8:00:00 PM	0
7/31/2015	8:15:00 PM	0
7/31/2015	8:30:00 PM	0
7/31/2015	8:45:00 PM	0
7/31/2015	9:00:00 PM	0
7/31/2015	9:15:00 PM	0
7/31/2015	9:30:00 PM	0.05
7/31/2015	9:45:00 PM	0.07
7/31/2015	10:00:00 PM	0.08
7/31/2015	10:15:00 PM	0.08
7/31/2015	10:30:00 PM	0.08
7/31/2015	10:45:00 PM	0.08
7/31/2015	11:00:00 PM	0.09
7/31/2015	11:15:00 PM	0.09
7/31/2015	11:30:00 PM	0.1
7/31/2015	11:45:00 PM	0.1

Party: MKH / PLL	Width: 22.0 ft	Processed by: MKH
Boat/Motor:	Area: 93.1 ft ²	Mean Velocity: 0.690 ft/s
Gage Height: 4.59 ft	G.H.Change: 0.000 ft	Discharge: 63.9 ft ³ /s

Area Method: Avg. Course	ADCP Depth: 0.164 ft	Index Vel.: 0.00 ft/s	Rating No.: 1
Nav. Method: Bottom Track	Shore Ens.:10	Adj.Mean Vel: 0.00 ft/s	Qm Rating: U
MagVar Method: None (0.0°)	Bottom Est: Power (0.1667)	Rated Area: 0.000 ft ²	Diff.: 0.000%
Depth Sounder: Not Used	Top Est: Power (0.1667)	Control1: Unspecified	
Discharge Method: None		Control2: Unspecified	
% Correction: 0.00		Control3: Unspecified	

Screening Thresholds:	ADCP:
BT 3-Beam Solution: NO	Type/Freq.: StreamPro / 2000 kHz
WT 3-Beam Solution: NO	Serial #: Firmware: 31.12
BT Error Vel.: 32.81 ft/s	Bin Size: 10 cm Blank: 3 cm
WT Error Vel.: 32.81 ft/s	BT Mode: 10 BT Pings: 2
BT Up Vel.: 32.81 ft/s	WT Mode: 12 WT Pings: 6
WT Up Vel.: 32.81 ft/s	WV : 0 WO : 1, 4
Use Weighted Mean Depth: NO	
Max. Vel.: 4.14 ft/s	
Max. Depth: 8.05 ft	
Mean Depth: 4.23 ft	
% Meas.: 69.24	
Water Temp.: None	
ADCP Temp.: 67.9 °F	

Performed Diag. Test: NO
 Performed Moving Bed Test: NO
 Performed Compass Calibration: NO Evaluation: NO
 Meas. Location:

Project Name: 150722 LOR @ REINHACKLE
 Software: 2.11

Tr.#		Edge Distance		#Ens.	Discharge						Width	Area	Time		Mean Vel.		% Bad	
		L	R		Top	Middle	Bottom	Left	Right	Total			Start	End	Boat	Water	Ens.	Bins
000	L	2	2	36	8.02	45.0	8.12	2.22	1.70	65.1	22	94	07:50	07:50	0.50	0.69	11	1
001	R	2	2	36	7.91	44.3	7.77	2.54	1.13	63.6	22	91	07:51	07:51	0.51	0.70	11	3
002	L	2	2	42	7.45	40.5	8.16	2.19	-1.80	56.4	24	102	07:52	07:52	0.50	0.55	26	2
003	R	2	2	33	8.16	45.9	10.6	1.91	1.73	68.3	21	91	07:53	07:53	0.54	0.75	6	0
004	L	2	2	34	8.02	45.0	8.09	2.44	1.70	65.2	22	91	07:54	07:54	0.54	0.72	9	0
006	L	2	2	35	8.05	45.1	8.16	2.37	1.45	65.1	21	90	07:56	07:57	0.53	0.73	11	0
Mean		2	2	36	7.93	44.3	8.48	2.28	0.983	63.9	22	93	Total	00:07	0.52	0.69	12	1
SDev		0	0	3	0.249	1.94	1.05	0.224	1.38	3.99	1.2	4.7			0.02	0.07		
SD/M		0.00	0.00	0.09	0.03	0.04	0.12	0.10	1.41	0.06	0.05	0.05			0.04	0.10		

Remarks:

Discharge for transects in *italics* have a total Q more than 5% from the mean

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	1	0	3	6	0.725	-0.066	3.783	0.01	0.007	0	42.6	39.6	75.7	133	123	0	34	31
2015	7	1	0	13	6	0.751	-0.066	3.78	0.013	0.01	0	43	39.6	75.7	134	124	0	34	32
2015	7	1	0	23	6	0.745	-0.056	3.78	0.013	0.01	0	43	39.6	75.7	134	124	0	34	32
2015	7	1	0	33	6	0.751	-0.082	3.78	0.01	0.007	0	43.4	40	76.5	134	124	0	33	31
2015	7	1	0	43	6	0.725	-0.098	3.776	0.013	0.01	0	42.6	40	75.7	133	124	0	34	31
2015	7	1	0	53	6	0.751	-0.062	3.776	0.016	0.013	0	42.6	39.6	76.1	133	123	0	34	31
2015	7	1	1	3	6	0.709	-0.092	3.77	0.013	0.01	0	42.6	39.6	74.8	133	123	0	34	31
2015	7	1	1	13	6	0.741	-0.098	3.766	0.013	0.01	0	43	40	72.2	134	124	0	34	31
2015	7	1	1	23	6	0.771	-0.095	3.76	0.01	0.007	0	43	40	65.4	134	124	0	34	31
2015	7	1	1	33	6	0.719	-0.092	3.753	0.013	0.01	0	43.9	40.4	67.1	136	126	0	34	32
2015	7	1	1	43	6	0.735	-0.118	3.747	0.013	0.01	0	43.4	40.4	68.4	135	125	0	34	31
2015	7	1	1	53	6	0.689	-0.102	3.743	0.01	0.007	0	43.9	40.4	71.4	136	126	0	34	32
2015	7	1	2	3	6	0.702	-0.092	3.743	0.01	0.007	0	43.9	40.9	73.5	136	126	0	34	31
2015	7	1	2	13	6	0.712	-0.102	3.74	0.01	0.007	0	43.4	40.4	74.8	135	126	0	34	32
2015	7	1	2	23	6	0.699	-0.095	3.737	0.01	0.007	0	43.4	40.9	71.4	135	126	0	34	31
2015	7	1	2	33	6	0.741	-0.092	3.737	0.013	0.01	0	44.3	40.9	74.8	136	126	0	33	31
2015	7	1	2	43	6	0.758	-0.085	3.734	0.01	0.007	0	43.4	40.4	74.8	135	125	0	34	31
2015	7	1	2	53	6	0.722	-0.062	3.73	0.01	0.007	0	43.4	40.4	75.7	135	125	0	34	31
2015	7	1	3	3	6	0.712	-0.069	3.727	0.016	0.016	0	43.9	40.9	74	136	126	0	34	31
2015	7	1	3	13	6	0.692	-0.092	3.724	0.013	0.01	0	43.4	40.4	72.7	135	125	0	34	31
2015	7	1	3	23	6	0.748	-0.095	3.711	0.013	0.01	0	43.4	40.4	72.2	135	125	0	34	31
2015	7	1	3	33	6	0.715	-0.102	3.707	0.01	0.007	0	43.4	40.9	72.2	135	126	0	34	31
2015	7	1	3	43	6	0.725	-0.102	3.704	0.013	0.01	0	43.4	40.4	74.4	135	126	0	34	32
2015	7	1	3	53	6	0.709	-0.102	3.701	0.016	0.013	0	43.4	40.9	75.7	135	126	0	34	31
2015	7	1	4	3	6	0.705	-0.072	3.698	0.013	0.01	0	43.4	40.4	75.7	135	126	0	34	32
2015	7	1	4	13	6	0.676	-0.085	3.698	0.01	0.007	0	43.9	41.3	75.7	136	127	0	34	31
2015	7	1	4	23	6	0.702	-0.098	3.694	0.013	0.01	0	43.4	40.4	77	135	126	0	34	32
2015	7	1	4	33	6	0.709	-0.115	3.691	0.01	0.007	0	43.4	40.9	75.3	135	126	0	34	31
2015	7	1	4	43	6	0.712	-0.082	3.688	0.013	0.01	0	43.4	40.9	74.4	135	126	0	34	31
2015	7	1	4	53	6	0.712	-0.085	3.684	0.01	0.007	0	43.4	40.9	72.7	135	126	0	34	31
2015	7	1	5	3	6	0.692	-0.062	3.671	0.016	0.013	0	43.4	40.4	71.4	135	126	0	34	32
2015	7	1	5	13	6	0.732	-0.056	3.668	0.01	0.007	0	44.7	41.7	72.7	137	128	0	33	31
2015	7	1	5	23	6	0.722	-0.089	3.665	0.016	0.013	0	44.3	41.7	73.1	137	128	0	34	31
2015	7	1	5	33	6	0.705	-0.072	3.661	0.01	0.007	0	44.3	41.7	74.8	137	128	0	34	31
2015	7	1	5	43	6	0.682	-0.066	3.658	0.01	0.007	0	44.3	41.3	55.5	137	127	0	34	31
2015	7	1	5	53	6	0.643	-0.098	3.655	0.013	0.01	0	49.9	46.9	47.7	150	141	0	34	32
2015	7	1	6	3	6	0.614	-0.066	3.648	0.013	0.01	0	52	48.6	44.7	155	145	0	34	32
2015	7	1	6	13	6	0.659	-0.049	3.648	0.013	0.01	0	52.5	49.9	44.3	156	147	0	34	31
2015	7	1	6	23	6	0.64	-0.066	3.648	0.013	0.01	0	53.3	50.3	46.9	158	149	0	34	32
2015	7	1	6	33	6	0.65	-0.046	3.642	0.013	0.01	0	53.8	49.5	43.4	159	147	0	34	32
2015	7	1	6	43	6	0.646	-0.075	3.635	0.016	0.013	0	52.5	48.6	46	156	144	0	34	31
2015	7	1	6	53	6	0.669	-0.075	3.632	0.013	0.01	0	51.2	47.3	46.4	153	141	0	34	31
2015	7	1	7	3	6	0.65	-0.079	3.629	0.013	0.01	0	50.7	46	47.3	151	139	0	33	32
2015	7	1	7	13	6	0.679	-0.069	3.625	0.013	0.01	0	49.5	45.2	49.9	149	137	0	34	32
2015	7	1	7	23	6	0.656	-0.062	3.622	0.01	0.007	0	49	45.2	52	148	136	0	34	31
2015	7	1	7	33	6	0.673	-0.089	3.619	0.01	0.007	0	48.6	44.7	51.2	147	135	0	34	31
2015	7	1	7	43	6	0.646	-0.082	3.615	0.013	0.01	0	47.7	43.9	51.6	145	133	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	1	7	53	6	0.702	-0.092	3.612	0.016	0.013	0	46.9	43	53.3	143	131	0	34	31
2015	7	1	8	3	6	0.633	-0.079	3.609	0.013	0.01	0	46.4	42.6	53.3	143	131	0	35	32
2015	7	1	8	13	6	0.604	-0.085	3.609	0.01	0.007	0	46.9	43.4	55	144	132	0	35	31
2015	7	1	8	23	6	0.64	-0.085	3.602	0.013	0.01	0	46.9	42.6	48.6	143	131	0	34	32
2015	7	1	8	33	6	0.64	-0.059	3.599	0.013	0.01	0	46.9	43	50.7	143	131	0	34	31
2015	7	1	8	43	6	0.633	-0.069	3.593	0.01	0.007	0	46.4	42.1	53.8	142	130	0	34	32
2015	7	1	8	53	6	0.669	-0.075	3.589	0.016	0.013	0	46.4	41.7	54.2	142	129	0	34	32
2015	7	1	9	3	6	0.653	-0.102	3.586	0.013	0.01	0	46	41.7	49.9	141	128	0	34	31
2015	7	1	9	13	6	0.656	-0.092	3.583	0.01	0.007	0	45.6	41.3	55.5	140	128	0	34	32
2015	7	1	9	23	6	0.64	-0.085	3.583	0.01	0.007	0	45.2	42.1	57.6	140	129	0	35	31
2015	7	1	9	33	6	0.663	-0.059	3.579	0.01	0.007	0	45.6	42.1	74.8	140	129	0	34	31
2015	7	1	9	43	6	0.686	-0.075	3.576	0.01	0.007	0	45.6	41.7	74.8	140	128	0	34	31
2015	7	1	9	53	6	0.64	-0.102	3.576	0.013	0.01	0	45.6	41.7	72.2	140	128	0	34	31
2015	7	1	10	3	6	0.659	-0.089	3.573	0.013	0.01	0	46	41.3	75.3	141	128	0	34	32
2015	7	1	10	13	6	0.679	-0.059	3.573	0.01	0.007	0	45.2	41.7	74	140	128	0	35	31
2015	7	1	10	23	6	0.663	-0.059	3.57	0.013	0.01	0	45.6	41.3	75.3	140	128	0	34	32
2015	7	1	10	33	6	0.676	-0.066	3.566	0.013	0.01	0	45.2	41.3	70.1	140	127	0	35	31
2015	7	1	10	43	6	0.65	-0.089	3.563	0.01	0.007	0	46.4	42.6	52	142	131	0	34	32
2015	7	1	10	53	6	0.696	-0.059	3.56	0.01	0.007	0	46.9	42.6	68.4	142	130	0	33	31
2015	7	1	11	3	6	0.673	-0.085	3.55	0.013	0.01	0	46.4	42.1	67.5	142	130	0	34	32
2015	7	1	11	13	6	0.673	-0.102	3.55	0.01	0.007	0	46.4	42.6	71.4	142	130	0	34	31
2015	7	1	11	23	6	0.692	-0.102	3.547	0.01	0.007	0	46	42.1	73.1	141	129	0	34	31
2015	7	1	11	33	6	0.663	-0.092	3.543	0.013	0.01	0	46	41.7	73.5	141	129	0	34	32
2015	7	1	11	43	6	0.689	-0.066	3.543	0.016	0.013	0	45.6	42.1	74.8	140	129	0	34	31
2015	7	1	11	53	6	0.666	-0.079	3.54	0.01	0.007	0	45.6	42.1	75.3	140	129	0	34	31
2015	7	1	12	3	6	0.643	-0.062	3.54	0.016	0.013	0	45.6	41.7	75.3	140	128	0	34	31
2015	7	1	12	13	6	0.666	-0.072	3.54	0.013	0.01	0	46	41.7	73.5	140	129	0	33	32
2015	7	1	12	23	6	0.666	-0.079	3.537	0.01	0.007	0	45.6	41.7	75.7	140	129	0	34	32
2015	7	1	12	33	6	0.64	-0.095	3.537	0.013	0.01	0	46	42.6	69.7	141	130	0	34	31
2015	7	1	12	43	6	0.659	-0.108	3.537	0.013	0.01	0	46	42.1	63.2	141	129	0	34	31
2015	7	1	12	53	6	0.656	-0.069	3.533	0.01	0.007	0	45.6	41.7	75.3	140	129	0	34	32
2015	7	1	13	3	6	0.646	-0.092	3.533	0.016	0.013	0	45.6	42.1	74.4	140	129	0	34	31
2015	7	1	13	13	6	0.65	-0.085	3.53	0.016	0.013	0	45.6	41.3	74	140	128	0	34	32
2015	7	1	13	23	6	0.653	-0.082	3.53	0.013	0.01	0	46	41.7	73.5	141	129	0	34	32
2015	7	1	13	33	6	0.659	-0.069	3.527	0.016	0.016	0	46.4	42.6	72.7	141	130	0	33	31
2015	7	1	13	43	6	0.712	-0.105	3.524	0.01	0.007	0	46.4	42.6	72.2	142	131	0	34	32
2015	7	1	13	53	6	0.705	-0.095	3.517	0.01	0.007	0	46	42.1	72.2	140	129	0	33	31
2015	7	1	14	3	6	0.673	-0.112	3.514	0.013	0.01	0	45.6	42.1	72.7	140	129	0	34	31
2015	7	1	14	13	6	0.63	-0.085	3.51	0.013	0.01	0	45.6	41.7	73.5	140	128	0	34	31
2015	7	1	14	23	6	0.663	-0.085	3.51	0.016	0.013	0	46	42.1	74.8	140	129	0	33	31
2015	7	1	14	33	6	0.676	-0.095	3.507	0.013	0.01	0	45.2	41.3	74.4	139	127	0	34	31
2015	7	1	14	43	6	0.62	-0.102	3.507	0.013	0.01	0	44.7	41.7	75.3	139	128	0	35	31
2015	7	1	14	53	6	0.656	-0.072	3.507	0.01	0.007	0	46	41.7	74.4	140	128	0	33	31
2015	7	1	15	3	6	0.656	-0.095	3.504	0.013	0.01	0	45.2	41.3	74.4	139	128	0	34	32
2015	7	1	15	13	6	0.627	-0.082	3.504	0.013	0.01	0	45.2	41.3	58	139	127	0	34	31
2015	7	1	15	23	6	0.64	-0.085	3.504	0.013	0.01	0	46	42.1	60.2	140	129	0	33	31
2015	7	1	15	33	6	0.659	-0.075	3.501	0.016	0.013	0	46.9	41.3	58.9	142	127	0	33	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	1	15	43	6	0.627	-0.095	3.504	0.016	0.013	0	46.9	41.7	53.3	143	128	0	34	31
2015	7	1	15	53	6	0.604	-0.102	3.501	0.013	0.01	0	46.4	41.3	56.8	142	127	0	34	31
2015	7	1	16	3	6	0.614	-0.052	3.501	0.016	0.013	0	46.4	41.7	55.9	142	128	0	34	31
2015	7	1	16	13	6	0.62	-0.069	3.497	0.013	0.01	0	46	41.3	54.6	141	127	0	34	31
2015	7	1	16	23	6	0.627	-0.115	3.501	0.01	0.007	0	46.9	40.9	54.6	142	127	0	33	32
2015	7	1	16	33	6	0.627	-0.066	3.497	0.01	0.007	0	46.4	41.7	53.8	142	128	0	34	31
2015	7	1	16	43	6	0.614	-0.115	3.494	0.016	0.013	0	46	41.3	52.9	141	127	0	34	31
2015	7	1	16	53	6	0.659	-0.128	3.494	0.013	0.01	0	46	40.9	55.9	141	126	0	34	31
2015	7	1	17	3	6	0.604	-0.066	3.491	0.01	0.007	0	45.2	40.9	55.5	140	126	0	35	31
2015	7	1	17	13	6	0.64	-0.079	3.491	0.013	0.01	0	46	40.9	54.6	141	126	0	34	31
2015	7	1	17	23	6	0.643	-0.115	3.491	0.016	0.013	0	45.6	40.4	67.1	140	125	0	34	31
2015	7	1	17	33	6	0.689	-0.062	3.491	0.01	0.007	0	46	40.4	70.1	141	126	0	34	32
2015	7	1	17	43	6	0.669	-0.085	3.488	0.013	0.01	0	46	40.9	69.7	141	126	0	34	31
2015	7	1	17	53	6	0.646	-0.062	3.488	0.016	0.013	0	46	40.9	69.2	141	126	0	34	31
2015	7	1	18	3	6	0.682	-0.095	3.484	0.013	0.01	0	46	40.9	65.4	141	126	0	34	31
2015	7	1	18	13	6	0.673	-0.105	3.481	0.013	0.01	0	46	40.9	68.8	141	126	0	34	31
2015	7	1	18	23	6	0.666	-0.102	3.481	0.01	0.007	0	46	40.9	72.7	141	126	0	34	31
2015	7	1	18	33	6	0.699	-0.062	3.478	0.016	0.013	0	46.4	40.9	70.5	142	126	0	34	31
2015	7	1	18	43	6	0.656	-0.072	3.478	0.013	0.01	0	46.4	40.9	72.7	142	126	0	34	31
2015	7	1	18	53	6	0.663	-0.092	3.478	0.016	0.013	0	46.4	40.9	73.1	142	126	0	34	31
2015	7	1	19	3	6	0.653	-0.069	3.474	0.013	0.01	0	46	40.9	73.1	141	126	0	34	31
2015	7	1	19	13	6	0.679	-0.085	3.474	0.013	0.01	0	46.4	40.4	73.1	141	126	0	33	32
2015	7	1	19	23	6	0.686	-0.092	3.474	0.013	0.01	0	46.4	41.3	73.5	142	127	0	34	31
2015	7	1	19	33	6	0.692	-0.059	3.474	0.013	0.01	0	46.4	41.3	73.5	142	127	0	34	31
2015	7	1	19	43	6	0.666	-0.089	3.474	0.01	0.007	0	46.4	41.3	73.5	142	127	0	34	31
2015	7	1	19	53	6	0.732	-0.092	3.474	0.013	0.01	0	46.4	41.3	73.5	142	127	0	34	31
2015	7	1	20	3	6	0.699	-0.082	3.474	0.016	0.016	0	46.4	41.3	74	142	127	0	34	31
2015	7	1	20	13	6	0.653	-0.069	3.474	0.016	0.013	0	46.9	41.3	74	143	127	0	34	31
2015	7	1	20	23	6	0.679	-0.056	3.474	0.013	0.01	0	46.9	41.7	73.1	143	128	0	34	31
2015	7	1	20	33	6	0.699	-0.079	3.474	0.013	0.01	0	46.9	41.3	74	143	128	0	34	32
2015	7	1	20	43	6	0.659	-0.075	3.474	0.01	0.007	0	47.3	42.1	73.1	144	129	0	34	31
2015	7	1	20	53	6	0.689	-0.082	3.474	0.013	0.01	0	47.3	41.7	73.1	143	128	0	33	31
2015	7	1	21	3	6	0.709	-0.082	3.474	0.016	0.013	0	47.3	41.7	74	143	128	0	33	31
2015	7	1	21	13	6	0.656	-0.039	3.474	0.013	0.01	0	46.9	40.9	73.5	143	127	0	34	32
2015	7	1	21	23	6	0.663	-0.079	3.474	0.016	0.016	0	46.9	41.7	73.5	143	128	0	34	31
2015	7	1	21	33	6	0.679	-0.092	3.474	0.013	0.01	0	46.4	40.9	74	142	127	0	34	32
2015	7	1	21	43	6	0.63	-0.059	3.474	0.016	0.013	0	48.2	43	70.5	146	131	0	34	31
2015	7	1	21	53	6	0.65	-0.046	3.474	0.01	0.007	0	48.6	42.6	71	147	131	0	34	32
2015	7	1	22	3	6	0.663	-0.079	3.474	0.013	0.01	0	47.7	42.6	72.2	145	130	0	34	31
2015	7	1	22	13	6	0.728	-0.075	3.474	0.01	0.007	0	47.3	42.1	72.7	144	129	0	34	31
2015	7	1	22	23	6	0.669	-0.098	3.474	0.013	0.01	0	47.3	41.7	72.7	144	128	0	34	31
2015	7	1	22	33	6	0.669	-0.052	3.478	0.016	0.013	0	47.3	41.3	73.5	143	127	0	33	31
2015	7	1	22	43	6	0.659	-0.075	3.478	0.013	0.01	0	46.9	41.3	72.7	143	128	0	34	32
2015	7	1	22	53	6	0.705	-0.072	3.478	0.01	0.007	0	46.4	41.3	72.7	142	127	0	34	31
2015	7	1	23	3	6	0.679	-0.092	3.481	0.016	0.013	0	47.3	41.3	72.2	143	127	0	33	31
2015	7	1	23	13	6	0.682	-0.102	3.481	0.013	0.01	0	46.4	41.3	71.4	142	127	0	34	31
2015	7	1	23	23	6	0.653	-0.125	3.484	0.016	0.013	0	46.9	41.3	72.2	142	126	0	33	30

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	1	23	33	6	0.686	-0.082	3.484	0.016	0.013	0	46	40.9	72.7	141	126	0	34	31
2015	7	1	23	43	6	0.699	-0.098	3.488	0.013	0.01	0	45.6	40.9	72.2	140	126	0	34	31
2015	7	1	23	53	6	0.679	-0.033	3.488	0.013	0.01	0	46	40.4	73.1	141	125	0	34	31
2015	7	2	0	3	6	0.692	-0.085	3.491	0.016	0.013	0	46	40.4	74	141	125	0	34	31
2015	7	2	0	13	6	0.692	-0.066	3.491	0.013	0.01	0	45.6	40.4	74	140	125	0	34	31
2015	7	2	0	23	6	0.702	-0.069	3.491	0.01	0.007	0	45.6	40.4	74	140	125	0	34	31
2015	7	2	0	33	6	0.673	-0.079	3.491	0.013	0.01	0	46	40.4	74	141	126	0	34	32
2015	7	2	0	43	6	0.692	-0.069	3.491	0.01	0.007	0	46	40.9	72.7	141	126	0	34	31
2015	7	2	0	53	6	0.673	-0.085	3.494	0.016	0.013	0	46.4	40.4	74.8	141	126	0	33	32
2015	7	2	1	3	6	0.692	-0.075	3.494	0.013	0.01	0	46	40.9	74.8	141	126	0	34	31
2015	7	2	1	13	6	0.659	-0.066	3.494	0.01	0.007	0	46.4	40.9	74	141	126	0	33	31
2015	7	2	1	23	6	0.623	-0.085	3.494	0.013	0.01	0	47.3	41.3	74.4	144	128	0	34	32
2015	7	2	1	33	6	0.689	-0.072	3.494	0.013	0.01	0	46.4	41.3	64.5	142	127	0	34	31
2015	7	2	1	43	6	0.686	-0.059	3.494	0.013	0.01	0	46.4	41.3	75.3	142	127	0	34	31
2015	7	2	1	53	6	0.699	-0.095	3.497	0.013	0.01	0	46.9	41.7	67.5	143	128	0	34	31
2015	7	2	2	3	6	0.653	-0.066	3.497	0.016	0.013	0	46.9	41.3	74.4	143	128	0	34	32
2015	7	2	2	13	6	0.643	-0.075	3.497	0.016	0.013	0	47.3	41.7	72.7	143	128	0	33	31
2015	7	2	2	23	6	0.663	-0.069	3.497	0.013	0.01	0	46.9	41.3	70.1	143	128	0	34	32
2015	7	2	2	33	6	0.676	-0.043	3.497	0.013	0.01	0	47.7	42.1	69.2	144	129	0	33	31
2015	7	2	2	43	6	0.666	-0.069	3.497	0.016	0.016	0	49	43.4	67.1	147	132	0	33	31
2015	7	2	2	53	6	0.689	-0.056	3.497	0.01	0.007	0	49	43.4	69.7	148	133	0	34	32
2015	7	2	3	3	6	0.692	-0.039	3.497	0.013	0.01	0	49	43	72.2	147	132	0	33	32
2015	7	2	3	13	6	0.702	-0.059	3.501	0.013	0.01	0	47.7	42.6	74.8	145	130	0	34	31
2015	7	2	3	23	6	0.676	-0.085	3.501	0.013	0.01	0	47.3	42.1	75.3	144	129	0	34	31
2015	7	2	3	33	6	0.725	-0.098	3.501	0.01	0.007	0	46.9	41.7	76.1	143	128	0	34	31
2015	7	2	3	43	6	0.702	-0.098	3.501	0.013	0.01	0	47.3	41.3	70.1	143	128	0	33	32
2015	7	2	3	53	6	0.673	-0.072	3.501	0.016	0.016	0	46.4	40.9	73.5	142	127	0	34	32
2015	7	2	4	3	6	0.663	-0.062	3.501	0.013	0.01	0	46.9	41.7	57.2	144	129	0	35	32
2015	7	2	4	13	6	0.659	-0.066	3.504	0.013	0.01	0	49.5	43.9	49.9	149	134	0	34	32
2015	7	2	4	23	6	0.679	-0.049	3.504	0.016	0.013	0	52.9	47.7	66.7	157	142	0	34	31
2015	7	2	4	33	6	0.673	-0.016	3.504	0.013	0.01	0	52	46.9	69.7	155	140	0	34	31
2015	7	2	4	43	6	0.692	-0.046	3.504	0.016	0.013	0	50.7	45.6	71.8	152	137	0	34	31
2015	7	2	4	53	6	0.673	-0.056	3.504	0.016	0.013	0	49.5	43.9	72.7	149	134	0	34	32
2015	7	2	5	3	6	0.689	-0.062	3.504	0.013	0.01	0	48.2	43	73.5	146	131	0	34	31
2015	7	2	5	13	6	0.705	-0.079	3.504	0.016	0.013	0	47.3	42.1	71.8	144	129	0	34	31
2015	7	2	5	23	6	0.689	-0.056	3.504	0.013	0.01	0	46.9	41.3	74.8	143	128	0	34	32
2015	7	2	5	33	6	0.705	-0.039	3.504	0.016	0.016	0	46.4	40.9	74.8	142	127	0	34	32
2015	7	2	5	43	6	0.699	-0.118	3.504	0.013	0.01	0	46.9	40.9	74.8	143	127	0	34	32
2015	7	2	5	53	6	0.666	-0.066	3.504	0.01	0.007	0	46.9	41.3	65.4	143	128	0	34	32
2015	7	2	6	3	6	0.679	-0.085	3.504	0.016	0.016	0	46.9	41.3	74.8	143	128	0	34	32
2015	7	2	6	13	6	0.659	-0.105	3.507	0.013	0.01	0	46.9	41.3	74	142	127	0	33	31
2015	7	2	6	23	6	0.656	-0.089	3.507	0.01	0.007	0	47.3	41.7	74.4	143	128	0	33	31
2015	7	2	6	33	6	0.676	-0.066	3.507	0.01	0.007	0	46.4	40.9	74	142	127	0	34	32
2015	7	2	6	43	6	0.705	-0.102	3.507	0.013	0.01	0	46.9	41.3	74.8	142	127	0	33	31
2015	7	2	6	53	6	0.702	-0.075	3.507	0.016	0.013	0	46.9	41.3	74.8	142	127	0	33	31
2015	7	2	7	3	6	0.673	-0.105	3.507	0.01	0.007	0	46	41.3	74.4	141	127	0	34	31
2015	7	2	7	13	6	0.712	-0.089	3.507	0.01	0.007	0	46	40.9	74.8	141	126	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	2	7	23	6	0.686	-0.108	3.507	0.013	0.01	0	46.4	41.3	74.8	142	127	0	34	31
2015	7	2	7	33	6	0.669	-0.098	3.507	0.013	0.01	0	46.4	40.9	73.5	142	127	0	34	32
2015	7	2	7	43	6	0.696	-0.075	3.507	0.013	0.01	0	46	40.9	75.3	141	126	0	34	31
2015	7	2	7	53	6	0.682	-0.072	3.507	0.013	0.01	0	46	40.9	74.8	141	126	0	34	31
2015	7	2	8	3	6	0.692	-0.069	3.507	0.016	0.016	0	46	40.9	74.4	141	126	0	34	31
2015	7	2	8	13	6	0.663	-0.082	3.507	0.013	0.01	0	46.4	41.3	74.4	142	127	0	34	31
2015	7	2	8	23	6	0.689	-0.082	3.507	0.013	0.01	0	46	40.4	74.8	141	126	0	34	32
2015	7	2	8	33	6	0.702	-0.098	3.507	0.016	0.013	0	45.6	40.9	75.3	141	126	0	35	31
2015	7	2	8	43	6	0.682	-0.089	3.507	0.013	0.01	0	46.4	41.3	75.3	142	127	0	34	31
2015	7	2	8	53	6	0.712	-0.072	3.507	0.01	0.007	0	46	41.3	74.4	141	127	0	34	31
2015	7	2	9	3	6	0.692	-0.062	3.507	0.013	0.01	0	46.4	41.3	74.8	142	127	0	34	31
2015	7	2	9	13	6	0.673	-0.118	3.507	0.013	0.01	0	46	40.4	75.3	141	126	0	34	32
2015	7	2	9	23	6	0.659	-0.095	3.507	0.013	0.01	0	46	40.4	74.8	141	125	0	34	31
2015	7	2	9	33	6	0.696	-0.082	3.507	0.013	0.01	0	45.6	40.9	74.8	141	126	0	35	31
2015	7	2	9	43	6	0.679	-0.135	3.504	0.013	0.01	0	46	41.3	75.3	141	127	0	34	31
2015	7	2	9	53	6	0.646	-0.085	3.504	0.01	0.007	0	46	40.4	75.7	141	126	0	34	32
2015	7	2	10	3	6	0.614	-0.082	3.504	0.016	0.016	0	46	40.9	73.1	141	126	0	34	31
2015	7	2	10	13	6	0.633	-0.085	3.504	0.013	0.01	0	46.4	40.9	73.1	142	126	0	34	31
2015	7	2	10	23	6	0.669	-0.069	3.504	0.01	0.007	0	46.4	41.3	75.7	142	127	0	34	31
2015	7	2	10	33	6	0.627	-0.085	3.504	0.013	0.01	0	46.9	41.7	75.3	143	128	0	34	31
2015	7	2	10	43	6	0.663	-0.069	3.504	0.013	0.01	0	46.9	41.3	74.8	142	128	0	33	32
2015	7	2	10	53	6	0.676	-0.075	3.504	0.013	0.01	0	47.3	40.9	75.7	143	127	0	33	32
2015	7	2	11	3	6	0.682	-0.095	3.504	0.016	0.013	0	46.9	41.3	74.8	143	127	0	34	31
2015	7	2	11	13	6	0.663	-0.062	3.504	0.01	0.007	0	47.3	40.9	75.7	143	127	0	33	32
2015	7	2	11	23	6	0.696	-0.072	3.504	0.016	0.013	0	47.3	41.3	75.3	144	128	0	34	32
2015	7	2	11	33	6	0.676	-0.052	3.504	0.013	0.01	0	47.3	41.7	76.1	144	128	0	34	31
2015	7	2	11	43	6	0.627	-0.085	3.504	0.016	0.013	0	46.9	41.7	75.3	143	128	0	34	31
2015	7	2	11	53	6	0.623	-0.085	3.504	0.013	0.01	0	47.7	42.6	75.3	145	130	0	34	31
2015	7	2	12	3	6	0.663	-0.118	3.504	0.016	0.016	0	47.7	42.6	76.5	145	130	0	34	31
2015	7	2	12	13	6	0.679	-0.085	3.504	0.01	0.007	0	47.7	42.1	75.3	144	129	0	33	31
2015	7	2	12	23	6	0.633	-0.039	3.504	0.013	0.01	0	46.4	42.1	75.7	143	129	0	35	31
2015	7	2	12	33	6	0.673	-0.089	3.504	0.013	0.01	0	46.9	41.7	76.1	143	129	0	34	32
2015	7	2	12	43	6	0.653	-0.082	3.504	0.016	0.013	0	46.4	41.3	76.5	142	127	0	34	31
2015	7	2	12	53	6	0.699	-0.075	3.504	0.016	0.013	0	46	40.4	77.4	141	126	0	34	32
2015	7	2	13	3	6	0.659	-0.092	3.501	0.016	0.013	0	46.4	41.3	76.5	142	127	0	34	31
2015	7	2	13	13	6	0.65	-0.079	3.504	0.013	0.01	0	46.9	41.3	76.5	142	127	0	33	31
2015	7	2	13	23	6	0.666	-0.059	3.501	0.016	0.016	0	46.4	41.3	77	142	127	0	34	31
2015	7	2	13	33	6	0.686	-0.082	3.501	0.016	0.013	0	46.4	41.3	76.5	142	127	0	34	31
2015	7	2	13	43	6	0.656	-0.069	3.501	0.013	0.01	0	47.3	41.3	75.3	143	127	0	33	31
2015	7	2	13	53	6	0.643	-0.052	3.501	0.016	0.013	0	46.9	41.3	76.5	143	128	0	34	32
2015	7	2	14	3	6	0.653	-0.075	3.501	0.016	0.013	0	46.9	41.7	75.3	143	128	0	34	31
2015	7	2	14	13	6	0.682	-0.082	3.501	0.016	0.013	0	46	40.9	75.7	141	126	0	34	31
2015	7	2	14	23	6	0.663	-0.085	3.497	0.013	0.01	0	48.2	42.1	56.8	146	130	0	34	32
2015	7	2	14	33	6	0.686	-0.026	3.501	0.016	0.013	0	49	43.9	73.5	148	134	0	34	32
2015	7	2	14	43	6	0.643	-0.02	3.501	0.013	0.01	0	49.5	44.3	74	149	134	0	34	31
2015	7	2	14	53	6	0.669	-0.039	3.497	0.013	0.01	0	49	43.4	74	147	132	0	33	31
2015	7	2	15	3	6	0.659	-0.082	3.497	0.016	0.013	0	47.7	42.6	74.4	145	130	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	2	15	13	6	0.699	-0.043	3.497	0.016	0.013	0	47.3	42.1	74.4	144	129	0	34	31
2015	7	2	15	23	6	0.663	-0.046	3.497	0.013	0.01	0	46.4	41.3	73.5	142	127	0	34	31
2015	7	2	15	33	6	0.64	-0.056	3.497	0.013	0.01	0	46.4	41.3	73.1	142	127	0	34	31
2015	7	2	15	43	6	0.653	-0.108	3.494	0.016	0.013	0	46.4	40.9	72.7	142	126	0	34	31
2015	7	2	15	53	6	0.643	-0.069	3.494	0.013	0.01	0	46	40.9	73.5	141	126	0	34	31
2015	7	2	16	3	6	0.669	-0.082	3.494	0.013	0.01	0	46	40.4	73.1	141	125	0	34	31
2015	7	2	16	13	6	0.656	-0.079	3.494	0.016	0.013	0	46	41.3	72.7	141	126	0	34	30
2015	7	2	16	23	6	0.659	-0.092	3.491	0.016	0.016	0	46	40.9	72.7	141	126	0	34	31
2015	7	2	16	33	6	0.64	-0.069	3.488	0.01	0.007	0	46	40.9	71.8	141	126	0	34	31
2015	7	2	16	43	6	0.64	-0.085	3.484	0.013	0.01	0	46	40.4	71.8	141	125	0	34	31
2015	7	2	16	53	6	0.666	-0.092	3.484	0.01	0.007	0	46	40.9	72.7	141	126	0	34	31
2015	7	2	17	3	6	0.63	-0.102	3.481	0.016	0.013	0	46.4	40.4	71.4	141	125	0	33	31
2015	7	2	17	13	6	0.643	-0.092	3.481	0.01	0.007	0	46	40.4	73.1	141	125	0	34	31
2015	7	2	17	23	6	0.663	-0.102	3.481	0.013	0.01	0	46	40	72.2	140	125	0	33	32
2015	7	2	17	33	6	0.617	-0.072	3.481	0.013	0.01	0	46	40.9	50.3	141	126	0	34	31
2015	7	2	17	43	6	0.636	-0.105	3.481	0.013	0.01	0	46.4	41.3	54.6	142	127	0	34	31
2015	7	2	17	53	6	0.633	-0.033	3.481	0.01	0.007	0	46.9	41.3	55	142	127	0	33	31
2015	7	2	18	3	6	0.656	-0.095	3.478	0.01	0.007	0	46	40.4	60.2	141	126	0	34	32
2015	7	2	18	13	6	0.682	-0.098	3.481	0.01	0.007	0	46	40.9	60.6	141	126	0	34	31
2015	7	2	18	23	6	0.63	-0.102	3.481	0.01	0.007	0	46.4	40.4	55.5	141	125	0	33	31
2015	7	2	18	33	6	0.653	-0.085	3.481	0.013	0.01	0	46	40.9	61.1	141	126	0	34	31
2015	7	2	18	43	6	0.696	-0.062	3.481	0.013	0.01	0	46	40.4	65.8	141	125	0	34	31
2015	7	2	18	53	6	0.682	-0.089	3.481	0.013	0.01	0	47.3	41.7	68.4	143	128	0	33	31
2015	7	2	19	3	6	0.679	-0.089	3.484	0.013	0.01	0	46	40.4	72.7	141	125	0	34	31
2015	7	2	19	13	6	0.686	-0.075	3.484	0.016	0.013	0	46.9	41.3	56.8	142	127	0	33	31
2015	7	2	19	23	6	0.656	-0.052	3.491	0.013	0.01	0	46	40.4	72.2	141	125	0	34	31
2015	7	2	19	33	6	0.643	-0.066	3.491	0.013	0.01	0	46	40.4	72.2	141	126	0	34	32
2015	7	2	19	43	6	0.666	-0.098	3.494	0.01	0.007	0	46	40.9	73.5	141	126	0	34	31
2015	7	2	19	53	6	0.702	-0.079	3.497	0.013	0.01	0	46.4	40.4	73.5	141	126	0	33	32
2015	7	2	20	3	6	0.686	-0.092	3.497	0.016	0.016	0	46	40.9	74	141	126	0	34	31
2015	7	2	20	13	6	0.696	-0.089	3.497	0.013	0.01	0	46.4	40.9	74.8	141	126	0	33	31
2015	7	2	20	23	6	0.719	-0.108	3.501	0.016	0.013	0	46.4	40.9	74.8	142	126	0	34	31
2015	7	2	20	33	6	0.653	-0.059	3.501	0.016	0.013	0	46.9	41.3	75.7	142	127	0	33	31
2015	7	2	20	43	6	0.669	-0.098	3.504	0.013	0.01	0	46	40.9	76.1	141	126	0	34	31
2015	7	2	20	53	6	0.699	-0.075	3.504	0.01	0.007	0	46	40.9	77	141	126	0	34	31
2015	7	2	21	3	6	0.646	-0.085	3.504	0.01	0.007	0	46.4	40.9	75.3	141	126	0	33	31
2015	7	2	21	13	6	0.699	-0.092	3.507	0.016	0.013	0	46	40.4	76.1	140	125	0	33	31
2015	7	2	21	23	6	0.712	-0.056	3.507	0.016	0.016	0	46	40.4	76.1	141	126	0	34	32
2015	7	2	21	33	6	0.696	-0.069	3.507	0.016	0.013	0	45.6	40.4	76.1	140	125	0	34	31
2015	7	2	21	43	6	0.702	-0.072	3.51	0.016	0.013	0	45.6	40.4	76.5	140	125	0	34	31
2015	7	2	21	53	6	0.696	-0.052	3.51	0.013	0.01	0	45.6	40.4	76.1	140	125	0	34	31
2015	7	2	22	3	6	0.663	-0.079	3.514	0.016	0.013	0	45.6	40	74.4	140	124	0	34	31
2015	7	2	22	13	6	0.673	-0.056	3.514	0.013	0.01	0	45.2	40	74.8	139	124	0	34	31
2015	7	2	22	23	6	0.702	-0.082	3.517	0.016	0.016	0	45.6	40	73.5	139	124	0	33	31
2015	7	2	22	33	6	0.689	-0.052	3.524	0.01	0.007	0	45.2	39.6	72.2	139	124	0	34	32
2015	7	2	22	43	6	0.699	-0.092	3.533	0.013	0.01	0	45.6	40	72.7	139	124	0	33	31
2015	7	2	22	53	6	0.656	-0.095	3.537	0.016	0.013	0	45.2	39.6	74.8	139	124	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	2	23	3	6	0.715	-0.075	3.54	0.016	0.013	0	45.2	39.6	74.4	138	123	0	33	31
2015	7	2	23	13	6	0.679	-0.062	3.54	0.013	0.01	0	45.6	40.4	76.1	140	125	0	34	31
2015	7	2	23	23	6	0.669	-0.082	3.543	0.013	0.01	0	45.6	40	72.2	140	124	0	34	31
2015	7	2	23	33	6	0.738	-0.072	3.543	0.01	0.007	0	45.2	39.6	77	139	123	0	34	31
2015	7	2	23	43	6	0.692	-0.066	3.543	0.01	0.007	0	47.3	42.1	57.6	144	129	0	34	31
2015	7	2	23	53	6	0.732	-0.062	3.547	0.016	0.016	0	46.4	40.9	74	142	126	0	34	31
2015	7	3	0	3	6	0.663	-0.089	3.553	0.016	0.013	0	45.6	40	75.3	140	124	0	34	31
2015	7	3	0	13	6	0.702	-0.092	3.553	0.013	0.01	0	45.6	39.6	74	139	124	0	33	32
2015	7	3	0	23	6	0.755	-0.069	3.56	0.016	0.013	0	45.6	40	72.7	139	124	0	33	31
2015	7	3	0	33	6	0.715	-0.102	3.57	0.013	0.01	0	45.2	40	73.1	139	124	0	34	31
2015	7	3	0	43	6	0.702	-0.115	3.573	0.016	0.013	0	45.2	40	75.3	139	124	0	34	31
2015	7	3	0	53	6	0.686	-0.043	3.576	0.013	0.01	0	45.6	40	75.7	140	124	0	34	31
2015	7	3	1	3	6	0.725	-0.069	3.579	0.013	0.01	0	45.6	40.4	76.1	140	125	0	34	31
2015	7	3	1	13	6	0.699	-0.069	3.583	0.013	0.01	0	46	40	75.7	140	124	0	33	31
2015	7	3	1	23	6	0.699	-0.092	3.583	0.01	0.007	0	44.7	40.4	76.5	139	125	0	35	31
2015	7	3	1	33	6	0.682	-0.046	3.586	0.016	0.013	0	45.6	40.4	75.7	140	125	0	34	31
2015	7	3	1	43	6	0.732	-0.082	3.589	0.01	0.007	0	45.6	40.4	75.3	140	125	0	34	31
2015	7	3	1	53	6	0.715	-0.075	3.593	0.02	0.016	0	46	40.4	74	140	125	0	33	31
2015	7	3	2	3	6	0.676	-0.098	3.596	0.013	0.01	0	45.2	40	73.1	139	124	0	34	31
2015	7	3	2	13	6	0.712	-0.118	3.609	0.01	0.007	0	45.2	40	72.7	139	124	0	34	31
2015	7	3	2	23	6	0.676	-0.092	3.612	0.016	0.016	0	45.6	40.4	74.4	140	125	0	34	31
2015	7	3	2	33	6	0.738	-0.089	3.615	0.01	0.007	0	45.2	40	75.7	139	124	0	34	31
2015	7	3	2	43	6	0.682	-0.072	3.619	0.016	0.013	0	45.6	40	77	139	124	0	33	31
2015	7	3	2	53	6	0.715	-0.072	3.622	0.016	0.013	0	45.2	40	76.5	139	125	0	34	32
2015	7	3	3	3	6	0.751	-0.069	3.622	0.013	0.01	0	46	40	75.7	140	125	0	33	32
2015	7	3	3	13	6	0.751	-0.082	3.625	0.013	0.01	0	46	40	75.7	140	125	0	33	32
2015	7	3	3	23	6	0.722	-0.079	3.629	0.013	0.01	0	45.6	40.4	74	139	125	0	33	31
2015	7	3	3	33	6	0.741	-0.059	3.629	0.013	0.01	0	45.6	40	74	140	125	0	34	32
2015	7	3	3	43	6	0.689	-0.079	3.632	0.016	0.013	0	45.2	40	73.1	139	124	0	34	31
2015	7	3	3	53	6	0.702	-0.082	3.645	0.013	0.01	0	46	40.4	72.7	140	125	0	33	31
2015	7	3	4	3	6	0.735	-0.059	3.648	0.016	0.013	0	45.6	40.4	74	140	125	0	34	31
2015	7	3	4	13	6	0.728	-0.052	3.655	0.013	0.01	0	45.6	40.9	74.8	141	126	0	35	31
2015	7	3	4	23	6	0.732	-0.098	3.658	0.013	0.01	0	45.2	40	75.7	139	124	0	34	31
2015	7	3	4	33	6	0.748	-0.082	3.658	0.01	0.007	0	45.2	40	76.1	139	124	0	34	31
2015	7	3	4	43	6	0.715	-0.062	3.661	0.013	0.01	0	46	40.4	75.3	140	125	0	33	31
2015	7	3	4	53	6	0.696	-0.046	3.661	0.01	0.007	0	45.6	40	74.4	139	124	0	33	31
2015	7	3	5	3	6	0.712	-0.052	3.665	0.013	0.01	0	45.6	40.4	75.3	140	125	0	34	31
2015	7	3	5	13	6	0.748	-0.069	3.665	0.01	0.007	0	45.6	40.4	74.8	140	125	0	34	31
2015	7	3	5	23	6	0.689	-0.056	3.668	0.01	0.007	0	46	40.9	74	141	126	0	34	31
2015	7	3	5	33	6	0.728	-0.112	3.671	0.013	0.01	0	46	40.4	72.7	141	126	0	34	32
2015	7	3	5	43	6	0.741	-0.082	3.678	0.016	0.016	0	46	40.9	72.7	141	126	0	34	31
2015	7	3	5	53	6	0.761	-0.082	3.688	0.013	0.01	0	46.4	40.4	73.5	142	126	0	34	32
2015	7	3	6	3	6	0.722	-0.082	3.691	0.016	0.013	0	46	40.4	74.8	141	125	0	34	31
2015	7	3	6	13	6	0.755	-0.089	3.694	0.013	0.01	0	46	39.6	75.7	141	125	0	34	33
2015	7	3	6	23	6	0.705	-0.082	3.698	0.016	0.016	0	46	40.4	76.5	141	125	0	34	31
2015	7	3	6	33	6	0.712	-0.062	3.698	0.01	0.007	0	46	40.4	76.1	140	125	0	33	31
2015	7	3	6	43	6	0.732	-0.069	3.698	0.013	0.01	0	46	40.4	75.7	141	125	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	3	6	53	6	0.715	-0.082	3.701	0.01	0.007	0	46.4	40.4	76.1	141	125	0	33	31
2015	7	3	7	3	6	0.741	-0.082	3.701	0.01	0.007	0	46	40.4	75.7	141	125	0	34	31
2015	7	3	7	13	6	0.725	-0.108	3.704	0.013	0.01	0	45.6	40.4	75.3	140	125	0	34	31
2015	7	3	7	23	6	0.732	-0.085	3.704	0.013	0.01	0	46	40	74.4	141	125	0	34	32
2015	7	3	7	33	6	0.768	-0.085	3.707	0.016	0.013	0	45.6	40.4	74.4	140	125	0	34	31
2015	7	3	7	43	6	0.686	-0.092	3.711	0.016	0.013	0	45.6	40	73.1	140	125	0	34	32
2015	7	3	7	53	6	0.755	-0.082	3.714	0.01	0.007	0	45.2	40	72.2	139	124	0	34	31
2015	7	3	8	3	6	0.732	-0.075	3.72	0.01	0.007	0	45.6	40	73.1	140	125	0	34	32
2015	7	3	8	13	6	0.761	-0.039	3.727	0.016	0.013	0	45.6	40	74	140	125	0	34	32
2015	7	3	8	23	6	0.715	-0.072	3.727	0.013	0.01	0	45.6	40.4	74.8	140	125	0	34	31
2015	7	3	8	33	6	0.755	-0.121	3.73	0.016	0.013	0	44.7	39.6	74.8	139	124	0	35	32
2015	7	3	8	43	6	0.741	-0.069	3.734	0.01	0.007	0	46	40.4	76.1	140	124	0	33	30
2015	7	3	8	53	6	0.768	-0.085	3.734	0.013	0.01	0	45.2	39.6	77	139	124	0	34	32
2015	7	3	9	3	6	0.722	-0.069	3.737	0.01	0.007	0	45.6	40.4	77	140	125	0	34	31
2015	7	3	9	13	6	0.722	-0.082	3.737	0.01	0.007	0	45.6	40.4	76.5	140	125	0	34	31
2015	7	3	9	23	6	0.715	-0.043	3.737	0.01	0.007	0	46	40.9	76.1	141	126	0	34	31
2015	7	3	9	33	6	0.764	-0.059	3.74	0.013	0.01	0	45.6	40.4	76.1	140	125	0	34	31
2015	7	3	9	43	6	0.751	-0.059	3.74	0.013	0.01	0	45.2	39.6	76.1	139	124	0	34	32
2015	7	3	9	53	6	0.748	-0.095	3.74	0.01	0.007	0	45.6	40.4	76.1	140	125	0	34	31
2015	7	3	10	3	6	0.741	-0.066	3.74	0.01	0.007	0	45.6	40.4	75.3	140	125	0	34	31
2015	7	3	10	13	6	0.735	-0.069	3.743	0.01	0.007	0	45.6	40.9	75.7	140	125	0	34	30
2015	7	3	10	23	6	0.771	-0.089	3.743	0.01	0.007	0	45.6	40	75.7	140	125	0	34	32
2015	7	3	10	33	6	0.732	-0.072	3.743	0.01	0.007	0	46	40.9	75.3	141	126	0	34	31
2015	7	3	10	43	6	0.741	-0.098	3.747	0.01	0.007	0	45.6	40.4	74.8	140	125	0	34	31
2015	7	3	10	53	6	0.794	-0.062	3.747	0.013	0.01	0	46	40	74.4	141	125	0	34	32
2015	7	3	11	3	6	0.751	-0.056	3.747	0.013	0.01	0	46	40.9	74.4	141	126	0	34	31
2015	7	3	11	13	6	0.719	-0.069	3.75	0.013	0.01	0	46	40.9	74	141	126	0	34	31
2015	7	3	11	23	6	0.692	-0.082	3.75	0.013	0.01	0	46	40.9	74	141	126	0	34	31
2015	7	3	11	33	6	0.728	-0.095	3.75	0.01	0.007	0	45.6	40	73.5	140	125	0	34	32
2015	7	3	11	43	6	0.709	-0.102	3.753	0.013	0.01	0	45.6	40.4	71.8	140	125	0	34	31
2015	7	3	11	53	6	0.702	-0.095	3.753	0.016	0.013	0	46	40.4	70.5	141	125	0	34	31
2015	7	3	12	3	6	0.692	-0.082	3.757	0.01	0.007	0	45.6	40.4	55	140	125	0	34	31
2015	7	3	12	13	6	0.669	-0.092	3.757	0.01	0.007	0	46	40	54.2	140	125	0	33	32
2015	7	3	12	23	6	0.715	-0.082	3.757	0.016	0.013	0	45.2	40.4	63.6	140	125	0	35	31
2015	7	3	12	33	6	0.715	-0.098	3.76	0.01	0.007	0	45.2	40.4	61.5	139	125	0	34	31
2015	7	3	12	43	6	0.735	-0.089	3.76	0.01	0.007	0	45.2	40.4	59.8	139	125	0	34	31
2015	7	3	12	53	6	0.705	-0.052	3.76	0.013	0.01	0	45.2	40	59.8	139	124	0	34	31
2015	7	3	13	3	6	0.656	-0.112	3.763	0.013	0.01	0	45.2	40	64.5	139	124	0	34	31
2015	7	3	13	13	6	0.722	-0.089	3.766	0.016	0.016	0	45.2	40.4	68.8	139	124	0	34	30
2015	7	3	13	23	6	0.669	-0.105	3.766	0.016	0.013	0	45.6	40.4	56.3	140	125	0	34	31
2015	7	3	13	33	6	0.679	-0.089	3.763	0.016	0.013	0	45.6	40.9	60.6	140	126	0	34	31
2015	7	3	13	43	6	0.738	-0.079	3.766	0.013	0.01	0	45.6	40.9	56.3	140	126	0	34	31
2015	7	3	13	53	6	0.735	-0.089	3.77	0.01	0.007	0	45.6	40.4	51.2	140	125	0	34	31
2015	7	3	14	3	6	0.771	-0.089	3.77	0.013	0.01	0	45.2	40	67.9	139	124	0	34	31
2015	7	3	14	13	6	0.712	-0.102	3.77	0.01	0.007	0	45.2	40.4	63.6	139	125	0	34	31
2015	7	3	14	23	6	0.732	-0.082	3.77	0.01	0.007	0	45.2	40	60.2	139	124	0	34	31
2015	7	3	14	33	6	0.705	-0.085	3.77	0.01	0.007	0	44.7	40	53.8	138	124	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	3	14	43	6	0.741	-0.095	3.77	0.013	0.01	0	45.2	40	56.8	139	124	0	34	31
2015	7	3	14	53	6	0.722	-0.046	3.77	0.013	0.01	0	45.6	40.4	61.1	140	125	0	34	31
2015	7	3	15	3	6	0.735	-0.085	3.77	0.013	0.01	0	45.6	40.4	52.9	140	125	0	34	31
2015	7	3	15	13	6	0.735	-0.079	3.773	0.013	0.01	0	45.6	40.4	58	139	125	0	33	31
2015	7	3	15	23	6	0.709	-0.115	3.77	0.01	0.007	0	46	40.4	55.5	141	125	0	34	31
2015	7	3	15	33	6	0.715	-0.108	3.773	0.013	0.01	0	46	40.4	64.5	140	125	0	33	31
2015	7	3	15	43	6	0.741	-0.079	3.776	0.01	0.007	0	45.2	39.6	69.2	139	124	0	34	32
2015	7	3	15	53	6	0.689	-0.085	3.773	0.01	0.007	0	45.2	40	54.2	138	124	0	33	31
2015	7	3	16	3	6	0.673	-0.085	3.773	0.013	0.01	0	44.7	40	57.2	138	124	0	34	31
2015	7	3	16	13	6	0.719	-0.079	3.773	0.013	0.01	0	45.2	40	55.5	139	124	0	34	31
2015	7	3	16	23	6	0.748	-0.092	3.773	0.013	0.01	0	45.2	40	59.8	139	124	0	34	31
2015	7	3	16	33	6	0.709	-0.115	3.773	0.01	0.007	0	44.7	40	54.2	138	124	0	34	31
2015	7	3	16	43	6	0.712	-0.085	3.776	0.01	0.007	0	44.7	39.6	62.4	138	123	0	34	31
2015	7	3	16	53	6	0.735	-0.085	3.776	0.01	0.007	0	45.2	39.6	64.9	138	123	0	33	31
2015	7	3	17	3	6	0.702	-0.095	3.776	0.013	0.01	0	44.7	39.1	60.2	138	123	0	34	32
2015	7	3	17	13	6	0.735	-0.105	3.776	0.016	0.013	0	44.7	40	68.4	138	124	0	34	31
2015	7	3	17	23	6	0.722	-0.069	3.776	0.01	0.007	0	44.7	39.6	63.6	138	123	0	34	31
2015	7	3	17	33	6	0.755	-0.069	3.78	0.01	0.007	0	44.7	39.6	57.2	138	123	0	34	31
2015	7	3	17	43	6	0.689	-0.108	3.78	0.016	0.013	0	44.7	39.1	60.2	138	123	0	34	32
2015	7	3	17	53	6	0.741	-0.085	3.78	0.013	0.01	0	45.2	40	61.5	138	123	0	33	30
2015	7	3	18	3	6	0.748	-0.069	3.78	0.013	0.01	0	44.7	39.1	73.5	138	123	0	34	32
2015	7	3	18	13	6	0.741	-0.085	3.78	0.013	0.01	0	44.7	39.6	66.7	138	123	0	34	31
2015	7	3	18	23	6	0.719	-0.105	3.783	0.01	0.007	0	44.7	39.6	67.1	138	123	0	34	31
2015	7	3	18	33	6	0.758	-0.072	3.78	0.013	0.01	0	46.4	41.3	64.1	142	127	0	34	31
2015	7	3	18	43	6	0.761	-0.046	3.776	0.01	0.007	0	49.5	44.3	40.9	149	134	0	34	31
2015	7	3	18	53	6	0.751	-0.112	3.776	0.013	0.01	0	45.2	40.4	49.9	139	125	0	34	31
2015	7	3	19	3	6	0.771	-0.052	3.783	0.016	0.013	0	47.3	42.1	47.7	144	129	0	34	31
2015	7	3	19	13	6	0.699	-0.075	3.776	0.01	0.007	0	50.3	45.6	42.1	151	137	0	34	31
2015	7	3	19	23	6	0.81	-0.033	3.78	0.013	0.01	0	47.3	43.9	40.9	144	134	0	34	32
2015	7	3	19	33	6	0.761	-0.089	3.78	0.01	0.007	0	47.3	43.9	42.6	144	133	0	34	31
2015	7	3	19	43	6	0.732	-0.082	3.786	0.013	0.01	0	45.6	42.1	43	140	130	0	34	32
2015	7	3	19	53	6	0.758	-0.075	3.786	0.013	0.01	0	44.3	40.9	46.4	137	126	0	34	31
2015	7	3	20	3	6	0.741	-0.062	3.783	0.013	0.01	0	46	43	47.7	140	131	0	33	31
2015	7	3	20	13	6	0.715	-0.085	3.783	0.013	0.01	0	44.3	41.3	51.2	137	128	0	34	32
2015	7	3	20	23	6	0.758	-0.148	3.783	0.013	0.01	0	40.9	43.4	43.4	129	132	0	34	31
2015	7	3	20	33	6	0.768	-0.079	3.789	0.01	0.007	0	37.4	40	75.7	121	124	0	34	31
2015	7	3	20	43	6	0.738	-0.082	3.789	0.016	0.016	0	37	39.6	74.8	120	124	0	34	32
2015	7	3	20	53	6	0.725	-0.082	3.789	0.01	0.007	0	37.4	40	73.1	121	124	0	34	31
2015	7	3	21	3	6	0.751	-0.098	3.789	0.01	0.007	0	37.4	40	75.3	120	124	0	33	31
2015	7	3	21	13	6	0.722	-0.066	3.789	0.01	0.007	0	36.5	39.1	74.8	119	123	0	34	32
2015	7	3	21	23	6	0.751	-0.128	3.789	0.013	0.01	0	36.5	39.6	74	119	123	0	34	31
2015	7	3	21	33	6	0.735	-0.089	3.793	0.01	0.007	0	37.4	39.1	73.5	120	122	0	33	31
2015	7	3	21	43	6	0.633	-0.184	3.793	0.013	0.01	0	36.5	39.1	74	119	122	0	34	31
2015	7	3	21	53	6	0.686	-0.164	3.793	0.01	0.007	0	36.5	39.1	73.1	119	122	0	34	31
2015	7	3	22	3	6	0.719	-0.112	3.793	0.01	0.007	0	36.5	38.7	73.1	119	122	0	34	32
2015	7	3	22	13	6	0.732	-0.171	3.793	0.01	0.007	0	36.1	38.7	73.1	118	121	0	34	31
2015	7	3	22	23	6	0.682	-0.167	3.796	0.016	0.013	0	36.5	38.7	73.1	118	121	0	33	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	3	22	33	6	0.673	-0.167	3.799	0.013	0.01	0	36.1	38.7	72.2	118	121	0	34	31
2015	7	3	22	43	6	0.699	-0.171	3.806	0.01	0.007	0	36.1	38.7	72.2	117	121	0	33	31
2015	7	3	22	53	6	0.643	-0.171	3.809	0.013	0.01	0	36.1	39.1	74	118	122	0	34	31
2015	7	3	23	3	6	0.676	-0.18	3.809	0.01	0.007	0	36.5	39.1	74	117	122	0	32	31
2015	7	3	23	13	6	0.666	-0.171	3.809	0.01	0.007	0	35.7	38.7	74.4	116	121	0	33	31
2015	7	3	23	23	6	0.699	-0.148	3.809	0.013	0.01	0	35.7	39.1	74.8	117	122	0	34	31
2015	7	3	23	33	6	0.636	-0.174	3.812	0.01	0.007	0	36.1	38.7	74.8	118	122	0	34	32
2015	7	3	23	43	6	0.65	-0.154	3.812	0.016	0.013	0	35.7	38.7	74.8	117	121	0	34	31
2015	7	3	23	53	6	0.65	-0.194	3.812	0.013	0.01	0	35.7	38.7	75.7	116	121	0	33	31
2015	7	4	0	3	6	0.65	-0.151	3.812	0.013	0.01	0	35.7	38.7	74.8	116	121	0	33	31
2015	7	4	0	13	6	0.669	-0.121	3.812	0.013	0.01	0	34.8	38.7	76.1	115	121	0	34	31
2015	7	4	0	23	6	0.735	-0.135	3.816	0.016	0.013	0	34.8	38.3	76.1	114	121	0	33	32
2015	7	4	0	33	6	0.719	-0.125	3.816	0.013	0.01	0	34.8	38.7	75.3	115	121	0	34	31
2015	7	4	0	43	6	0.676	-0.105	3.816	0.016	0.013	0	34.8	38.7	76.5	115	121	0	34	31
2015	7	4	0	53	6	0.728	-0.069	3.816	0.01	0.007	0	34.8	38.3	76.5	115	120	0	34	31
2015	7	4	1	3	6	0.735	-0.118	3.816	0.01	0.007	0	34.8	38.3	77.4	115	121	0	34	32
2015	7	4	1	13	6	0.761	-0.112	3.819	0.013	0.01	0	34.8	38.7	77	115	121	0	34	31
2015	7	4	1	23	6	0.768	-0.082	3.819	0.01	0.007	0	34.4	38.7	77.4	114	121	0	34	31
2015	7	4	1	33	6	0.761	-0.089	3.819	0.016	0.013	0	35.3	38.7	77	115	121	0	33	31
2015	7	4	1	43	6	0.751	-0.135	3.819	0.01	0.007	0	35.7	38.7	76.5	116	121	0	33	31
2015	7	4	1	53	6	0.686	-0.108	3.819	0.016	0.013	0	34.8	38.3	77	115	121	0	34	32
2015	7	4	2	3	6	0.705	-0.095	3.819	0.01	0.007	0	34.8	38.7	77	115	121	0	34	31
2015	7	4	2	13	6	0.715	-0.151	3.819	0.016	0.013	0	35.3	39.1	76.1	116	122	0	34	31
2015	7	4	2	23	6	0.712	-0.121	3.819	0.016	0.013	0	35.7	39.1	77	116	122	0	33	31
2015	7	4	2	33	6	0.741	-0.085	3.819	0.01	0.007	0	35.3	39.6	76.5	115	122	0	33	30
2015	7	4	2	43	6	0.741	-0.102	3.819	0.01	0.007	0	34.8	38.7	76.5	115	121	0	34	31
2015	7	4	2	53	6	0.692	-0.115	3.822	0.013	0.01	0	35.3	39.1	76.1	116	122	0	34	31
2015	7	4	3	3	6	0.702	-0.131	3.819	0.013	0.01	0	35.3	38.3	76.1	116	121	0	34	32
2015	7	4	3	13	6	0.761	-0.161	3.822	0.016	0.013	0	34.8	38.7	76.5	115	121	0	34	31
2015	7	4	3	23	6	0.65	-0.141	3.822	0.013	0.01	0	35.7	39.1	76.1	116	122	0	33	31
2015	7	4	3	33	6	0.751	-0.079	3.819	0.013	0.01	0	35.3	38.7	65.4	116	121	0	34	31
2015	7	4	3	43	6	0.679	-0.112	3.822	0.013	0.01	0	36.5	38.7	75.7	118	122	0	33	32
2015	7	4	3	53	6	0.673	-0.135	3.822	0.016	0.013	0	36.5	39.1	75.3	118	122	0	33	31
2015	7	4	4	3	6	0.643	-0.187	3.822	0.01	0.007	0	37	39.1	76.1	120	122	0	34	31
2015	7	4	4	13	6	0.604	-0.164	3.822	0.01	0.007	0	37.4	38.7	77	120	122	0	33	32
2015	7	4	4	23	6	0.715	-0.121	3.822	0.01	0.007	0	36.1	39.1	75.7	119	122	0	35	31
2015	7	4	4	33	6	0.682	-0.141	3.822	0.016	0.013	0	37	39.6	73.5	120	123	0	34	31
2015	7	4	4	43	6	0.692	-0.131	3.822	0.01	0.007	0	37.4	39.6	74.8	120	123	0	33	31
2015	7	4	4	53	6	0.65	-0.154	3.822	0.013	0.01	0	37.4	39.6	74.8	121	123	0	34	31
2015	7	4	5	3	6	0.699	-0.167	3.822	0.016	0.013	0	37	39.6	74.8	120	123	0	34	31
2015	7	4	5	13	6	0.679	-0.187	3.822	0.013	0.01	0	37	39.6	75.7	120	123	0	34	31
2015	7	4	5	23	6	0.669	-0.187	3.822	0.016	0.013	0	37	39.6	75.3	120	123	0	34	31
2015	7	4	5	33	6	0.679	-0.19	3.825	0.016	0.013	0	37	40	74.4	120	124	0	34	31
2015	7	4	5	43	6	0.646	-0.171	3.825	0.013	0.01	0	36.5	40	75.3	119	124	0	34	31
2015	7	4	5	53	6	0.676	-0.154	3.825	0.01	0.007	0	36.5	40	74.8	119	124	0	34	31
2015	7	4	6	3	6	0.679	-0.18	3.825	0.016	0.013	0	36.5	39.6	74	119	123	0	34	31
2015	7	4	6	13	6	0.722	-0.118	3.825	0.016	0.013	0	37	39.6	74	119	123	0	33	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	4	6	23	6	0.692	-0.148	3.825	0.01	0.007	0	37	39.6	74	119	123	0	33	31
2015	7	4	6	33	6	0.676	-0.171	3.825	0.013	0.01	0	37	39.6	74.4	120	123	0	34	31
2015	7	4	6	43	6	0.679	-0.144	3.825	0.016	0.013	0	37	39.6	74.4	120	123	0	34	31
2015	7	4	6	53	6	0.663	-0.18	3.825	0.01	0.007	0	37	39.1	74.4	120	122	0	34	31
2015	7	4	7	3	6	0.712	-0.138	3.825	0.01	0.007	0	37.4	39.1	74	120	122	0	33	31
2015	7	4	7	13	6	0.725	-0.148	3.829	0.016	0.016	0	37	39.6	74	120	123	0	34	31
2015	7	4	7	23	6	0.692	-0.157	3.829	0.01	0.007	0	37.4	39.6	73.5	120	123	0	33	31
2015	7	4	7	33	6	0.722	-0.135	3.829	0.013	0.01	0	36.5	39.1	73.5	118	122	0	33	31
2015	7	4	7	43	6	0.63	-0.164	3.829	0.01	0.007	0	36.5	39.1	74	119	122	0	34	31
2015	7	4	7	53	6	0.676	-0.148	3.829	0.01	0.007	0	37	38.7	74	119	122	0	33	32
2015	7	4	8	3	6	0.738	-0.105	3.829	0.01	0.007	0	36.1	39.1	72.7	118	122	0	34	31
2015	7	4	8	13	6	0.699	-0.118	3.829	0.016	0.013	0	36.5	39.6	72.7	119	123	0	34	31
2015	7	4	8	23	6	0.663	-0.135	3.829	0.013	0.01	0	36.5	38.7	73.5	119	122	0	34	32
2015	7	4	8	33	6	0.663	-0.121	3.829	0.01	0.007	0	36.5	39.1	73.1	119	122	0	34	31
2015	7	4	8	43	6	0.646	-0.151	3.829	0.01	0.007	0	36.5	39.6	73.5	119	123	0	34	31
2015	7	4	8	53	6	0.719	-0.125	3.829	0.013	0.01	0	37	39.6	71	120	123	0	34	31
2015	7	4	9	3	6	0.712	-0.118	3.829	0.016	0.013	0	37	39.6	72.2	120	123	0	34	31
2015	7	4	9	13	6	0.676	-0.131	3.829	0.016	0.013	0	37.4	39.6	73.1	121	123	0	34	31
2015	7	4	9	23	6	0.712	-0.135	3.829	0.01	0.007	0	37.4	39.6	73.1	121	123	0	34	31
2015	7	4	9	33	6	0.699	-0.135	3.832	0.016	0.016	0	38.3	39.6	72.7	122	123	0	33	31
2015	7	4	9	43	6	0.676	-0.131	3.829	0.016	0.013	0	37.8	39.1	72.2	121	123	0	33	32
2015	7	4	9	53	6	0.712	-0.112	3.829	0.01	0.007	0	37.8	39.6	73.1	121	123	0	33	31
2015	7	4	10	3	6	0.676	-0.148	3.829	0.01	0.007	0	37	39.6	72.2	120	123	0	34	31
2015	7	4	10	13	6	0.673	-0.144	3.829	0.013	0.01	0	37	38.7	72.7	120	122	0	34	32
2015	7	4	10	23	6	0.653	-0.141	3.829	0.01	0.007	0	37	39.1	73.5	120	122	0	34	31
2015	7	4	10	33	6	0.676	-0.131	3.829	0.016	0.013	0	38.3	39.6	73.1	122	123	0	33	31
2015	7	4	10	43	6	0.751	-0.108	3.829	0.016	0.016	0	37.4	40	73.5	121	124	0	34	31
2015	7	4	10	53	6	0.686	-0.082	3.829	0.013	0.01	0	36.5	39.6	72.2	119	123	0	34	31
2015	7	4	11	3	6	0.722	-0.118	3.829	0.01	0.007	0	36.5	39.1	70.5	119	123	0	34	32
2015	7	4	11	13	6	0.673	-0.135	3.829	0.01	0.007	0	37.4	40	71.4	120	124	0	33	31
2015	7	4	11	23	6	0.748	-0.118	3.829	0.016	0.013	0	36.5	39.6	69.2	119	123	0	34	31
2015	7	4	11	33	6	0.741	-0.102	3.829	0.01	0.007	0	36.1	38.7	71.8	118	122	0	34	32
2015	7	4	11	43	6	0.725	-0.092	3.829	0.01	0.007	0	36.5	39.6	74.4	119	123	0	34	31
2015	7	4	11	53	6	0.784	-0.072	3.829	0.01	0.007	0	35.7	39.1	74.4	117	122	0	34	31
2015	7	4	12	3	6	0.712	-0.102	3.825	0.016	0.013	0	36.1	39.1	71.8	118	122	0	34	31
2015	7	4	12	13	6	0.751	-0.141	3.829	0.016	0.013	0	36.1	39.1	73.1	118	122	0	34	31
2015	7	4	12	23	6	0.702	-0.108	3.829	0.01	0.007	0	36.5	39.1	73.1	118	123	0	33	32
2015	7	4	12	33	6	0.709	-0.115	3.829	0.013	0.01	0	36.1	39.1	74.8	118	122	0	34	31
2015	7	4	12	43	6	0.768	-0.098	3.829	0.016	0.013	0	35.3	38.7	73.1	116	121	0	34	31
2015	7	4	12	53	6	0.725	-0.085	3.829	0.01	0.007	0	35.3	38.7	74.4	116	121	0	34	31
2015	7	4	13	3	6	0.728	-0.062	3.829	0.013	0.01	0	35.3	38.7	74	116	121	0	34	31
2015	7	4	13	13	6	0.709	-0.148	3.829	0.013	0.01	0	36.5	38.7	74.8	119	122	0	34	32
2015	7	4	13	23	6	0.719	-0.125	3.829	0.01	0.007	0	36.5	39.1	71.8	119	122	0	34	31
2015	7	4	13	33	6	0.748	-0.102	3.829	0.016	0.013	0	36.1	38.7	74.8	118	121	0	34	31
2015	7	4	13	43	6	0.719	-0.092	3.829	0.01	0.007	0	36.1	38.3	74.8	118	121	0	34	32
2015	7	4	13	53	6	0.728	-0.128	3.829	0.016	0.013	0	36.5	38.7	75.3	119	121	0	34	31
2015	7	4	14	3	6	0.748	-0.085	3.829	0.013	0.01	0	37	39.1	74.8	119	122	0	33	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	4	14	13	6	0.702	-0.105	3.829	0.01	0.007	0	36.5	38.7	75.3	119	121	0	34	31
2015	7	4	14	23	6	0.705	-0.135	3.829	0.013	0.01	0	36.5	39.1	74.8	119	121	0	34	30
2015	7	4	14	33	6	0.699	-0.18	3.829	0.013	0.01	0	37	39.1	75.3	119	122	0	33	31
2015	7	4	14	43	6	0.702	-0.121	3.829	0.013	0.01	0	36.5	39.1	67.5	119	122	0	34	31
2015	7	4	14	53	6	0.722	-0.118	3.829	0.013	0.01	0	37	38.7	54.2	120	122	0	34	32
2015	7	4	15	3	6	0.702	-0.118	3.829	0.01	0.007	0	37.4	39.1	74	120	122	0	33	31
2015	7	4	15	13	6	0.676	-0.121	3.829	0.01	0.007	0	36.5	39.1	74.4	119	122	0	34	31
2015	7	4	15	23	6	0.709	-0.148	3.829	0.016	0.013	0	36.5	39.1	75.3	119	121	0	34	30
2015	7	4	15	33	6	0.699	-0.154	3.829	0.01	0.007	0	37	39.1	69.7	119	122	0	33	31
2015	7	4	15	43	6	0.719	-0.112	3.829	0.01	0.007	0	37	39.6	74	120	123	0	34	31
2015	7	4	15	53	6	0.722	-0.115	3.829	0.016	0.016	0	36.5	38.7	71.8	119	122	0	34	32
2015	7	4	16	3	6	0.686	-0.115	3.829	0.013	0.01	0	36.1	38.7	72.2	118	121	0	34	31
2015	7	4	16	13	6	0.738	-0.098	3.829	0.013	0.01	0	38.3	40.9	55.9	123	126	0	34	31
2015	7	4	16	23	6	0.728	-0.102	3.829	0.01	0.007	0	40	43	58	127	131	0	34	31
2015	7	4	16	33	6	0.738	-0.056	3.829	0.01	0.007	0	39.6	43	55.9	127	131	0	35	31
2015	7	4	16	43	6	0.725	-0.102	3.829	0.01	0.007	0	40	43	56.3	127	131	0	34	31
2015	7	4	16	53	6	0.735	-0.089	3.829	0.01	0.007	0	40.4	43.4	64.1	128	132	0	34	31
2015	7	4	17	3	6	0.745	-0.105	3.829	0.01	0.007	0	39.1	42.1	71	125	129	0	34	31
2015	7	4	17	13	6	0.774	-0.102	3.829	0.013	0.01	0	38.3	41.3	67.1	123	127	0	34	31
2015	7	4	17	23	6	0.725	-0.115	3.829	0.01	0.007	0	37.4	40.9	73.5	121	126	0	34	31
2015	7	4	17	33	6	0.722	-0.128	3.829	0.01	0.007	0	37.4	39.6	60.6	121	124	0	34	32
2015	7	4	17	43	6	0.699	-0.151	3.829	0.013	0.01	0	37.8	40	52	122	125	0	34	32
2015	7	4	17	53	6	0.705	-0.128	3.832	0.01	0.007	0	39.6	42.1	51.6	125	129	0	33	31
2015	7	4	18	3	6	0.725	-0.115	3.829	0.01	0.007	0	38.7	42.1	57.2	124	129	0	34	31
2015	7	4	18	13	6	0.738	-0.105	3.832	0.016	0.013	0	38.7	41.7	56.3	123	127	0	33	30
2015	7	4	18	23	6	0.732	-0.085	3.832	0.016	0.013	0	37.8	40.9	60.2	122	127	0	34	32
2015	7	4	18	33	6	0.699	-0.098	3.835	0.016	0.013	0	39.1	41.3	52.9	124	127	0	33	31
2015	7	4	18	43	6	0.787	-0.105	3.835	0.01	0.007	0	38.3	41.3	61.1	122	127	0	33	31
2015	7	4	18	53	6	0.732	-0.102	3.832	0.013	0.01	0	42.1	40.9	68.4	132	126	0	34	31
2015	7	4	19	3	6	0.705	-0.056	3.835	0.016	0.013	0	46	40.4	72.2	139	125	0	32	31
2015	7	4	19	13	6	0.745	-0.056	3.839	0.01	0.007	0	44.3	40	71	137	124	0	34	31
2015	7	4	19	23	6	0.735	-0.089	3.839	0.013	0.01	0	44.7	40.4	71.4	138	125	0	34	31
2015	7	4	19	33	6	0.751	-0.085	3.842	0.01	0.007	0	44.3	39.6	71.8	137	124	0	34	32
2015	7	4	19	43	6	0.771	-0.089	3.842	0.013	0.01	0	44.3	39.6	72.2	137	124	0	34	32
2015	7	4	19	53	6	0.728	-0.069	3.845	0.013	0.01	0	44.3	40	73.5	137	124	0	34	31
2015	7	4	20	3	6	0.712	-0.118	3.848	0.013	0.01	0	44.3	40	74	137	124	0	34	31
2015	7	4	20	13	6	0.768	-0.092	3.848	0.01	0.007	0	44.3	39.6	73.5	137	124	0	34	32
2015	7	4	20	23	6	0.755	-0.089	3.848	0.013	0.01	0	44.7	39.6	74.4	137	124	0	33	32
2015	7	4	20	33	6	0.748	-0.075	3.848	0.01	0.007	0	44.3	39.6	74.4	137	123	0	34	31
2015	7	4	20	43	6	0.741	-0.092	3.848	0.016	0.013	0	44.3	40	71.8	137	124	0	34	31
2015	7	4	20	53	6	0.755	-0.052	3.848	0.016	0.013	0	44.3	40	71.8	137	124	0	34	31
2015	7	4	21	3	6	0.738	-0.105	3.848	0.01	0.007	0	43.9	39.6	74.8	136	123	0	34	31
2015	7	4	21	13	6	0.778	-0.089	3.852	0.013	0.01	0	43.4	38.7	74.4	135	122	0	34	32
2015	7	4	21	23	6	0.761	-0.082	3.852	0.01	0.007	0	43.9	39.1	74	136	122	0	34	31
2015	7	4	21	33	6	0.722	-0.082	3.852	0.01	0.007	0	43.9	39.1	75.3	136	122	0	34	31
2015	7	4	21	43	6	0.761	-0.069	3.852	0.01	0.007	0	43.4	38.3	74.8	134	121	0	33	32
2015	7	4	21	53	6	0.748	-0.085	3.852	0.01	0.007	0	43	38.7	76.1	134	121	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	4	22	3	6	0.768	-0.052	3.852	0.013	0.01	0	43.4	38.7	76.1	135	121	0	34	31
2015	7	4	22	13	6	0.761	-0.049	3.852	0.01	0.007	0	43.4	38.7	76.1	135	121	0	34	31
2015	7	4	22	23	6	0.741	-0.059	3.852	0.01	0.007	0	43.4	38.7	77	135	121	0	34	31
2015	7	4	22	33	6	0.791	-0.062	3.855	0.01	0.007	0	42.6	37.8	76.1	133	119	0	34	31
2015	7	4	22	43	6	0.751	-0.098	3.852	0.013	0.01	0	43.4	38.7	76.5	135	121	0	34	31
2015	7	4	22	53	6	0.755	-0.079	3.855	0.01	0.007	0	43	38.3	77.4	134	120	0	34	31
2015	7	4	23	3	6	0.751	-0.098	3.855	0.01	0.007	0	43.4	37.4	77.4	134	119	0	33	32
2015	7	4	23	13	6	0.755	-0.089	3.855	0.01	0.007	0	43	38.7	76.5	134	120	0	34	30
2015	7	4	23	23	6	0.778	-0.082	3.855	0.01	0.007	0	43	38.3	77	134	120	0	34	31
2015	7	4	23	33	6	0.745	-0.072	3.855	0.013	0.01	0	43.9	38.7	77	135	121	0	33	31
2015	7	4	23	43	6	0.751	-0.082	3.855	0.01	0.007	0	43	38.3	77	134	120	0	34	31
2015	7	4	23	53	6	0.732	-0.066	3.855	0.013	0.01	0	43.4	38.3	76.5	135	120	0	34	31
2015	7	5	0	3	6	0.764	-0.082	3.855	0.013	0.01	0	43	38.3	77.4	134	120	0	34	31
2015	7	5	0	13	6	0.764	-0.075	3.855	0.013	0.01	0	43	38.3	77.4	134	120	0	34	31
2015	7	5	0	23	6	0.764	-0.066	3.855	0.01	0.007	0	43	38.3	77.4	134	120	0	34	31
2015	7	5	0	33	6	0.758	-0.082	3.855	0.016	0.013	0	43	38.7	77.4	134	120	0	34	30
2015	7	5	0	43	6	0.784	-0.092	3.855	0.016	0.013	0	43	38.3	76.1	134	120	0	34	31
2015	7	5	0	53	6	0.784	-0.062	3.858	0.01	0.007	0	43.4	38.3	77	134	120	0	33	31
2015	7	5	1	3	6	0.738	-0.056	3.855	0.01	0.007	0	43	37.8	76.5	134	120	0	34	32
2015	7	5	1	13	6	0.761	-0.049	3.858	0.01	0.007	0	43.4	38.7	76.5	135	121	0	34	31
2015	7	5	1	23	6	0.745	-0.062	3.858	0.01	0.007	0	43	38.7	75.7	134	121	0	34	31
2015	7	5	1	33	6	0.755	-0.069	3.858	0.016	0.013	0	43.4	38.7	76.1	135	121	0	34	31
2015	7	5	1	43	6	0.751	-0.059	3.858	0.01	0.007	0	43.4	38.3	75.3	135	120	0	34	31
2015	7	5	1	53	6	0.791	-0.098	3.858	0.01	0.007	0	43.4	38.3	76.1	135	121	0	34	32
2015	7	5	2	3	6	0.761	-0.072	3.858	0.01	0.007	0	43.9	39.1	75.7	136	122	0	34	31
2015	7	5	2	13	6	0.751	-0.085	3.858	0.01	0.007	0	43.4	38.7	76.1	135	121	0	34	31
2015	7	5	2	23	6	0.728	-0.079	3.858	0.013	0.01	0	43.4	38.7	75.3	135	122	0	34	32
2015	7	5	2	33	6	0.751	-0.098	3.858	0.013	0.01	0	43.9	39.1	75.3	136	122	0	34	31
2015	7	5	2	43	6	0.758	-0.069	3.858	0.01	0.007	0	43.9	39.1	75.3	136	122	0	34	31
2015	7	5	2	53	6	0.761	-0.085	3.858	0.013	0.01	0	43.9	39.1	75.7	135	122	0	33	31
2015	7	5	3	3	6	0.748	-0.069	3.858	0.013	0.01	0	43.9	38.7	75.7	136	122	0	34	32
2015	7	5	3	13	6	0.761	-0.069	3.858	0.01	0.007	0	43.9	39.1	74.8	136	122	0	34	31
2015	7	5	3	23	6	0.751	-0.066	3.858	0.016	0.013	0	43.9	39.1	74.8	136	122	0	34	31
2015	7	5	3	33	6	0.735	-0.066	3.858	0.01	0.007	0	43.9	38.7	75.3	136	122	0	34	32
2015	7	5	3	43	6	0.781	-0.082	3.858	0.01	0.007	0	43.4	38.7	74.4	135	121	0	34	31
2015	7	5	3	53	6	0.801	-0.095	3.862	0.01	0.007	0	43.4	38.7	75.3	135	121	0	34	31
2015	7	5	4	3	6	0.778	-0.056	3.862	0.01	0.007	0	43.4	39.1	75.3	135	122	0	34	31
2015	7	5	4	13	6	0.758	-0.095	3.862	0.01	0.007	0	43.9	39.1	75.3	136	122	0	34	31
2015	7	5	4	23	6	0.732	-0.072	3.862	0.01	0.007	0	43.4	39.1	74	135	122	0	34	31
2015	7	5	4	33	6	0.745	-0.079	3.862	0.01	0.007	0	43.4	38.7	73.5	135	121	0	34	31
2015	7	5	4	43	6	0.764	-0.082	3.862	0.016	0.016	0	43.4	38.3	74.4	134	120	0	33	31
2015	7	5	4	53	6	0.781	-0.072	3.862	0.01	0.007	0	43.4	38.7	74	135	121	0	34	31
2015	7	5	5	3	6	0.728	-0.066	3.862	0.01	0.007	0	43.9	38.7	73.1	135	121	0	33	31
2015	7	5	5	13	6	0.764	-0.105	3.862	0.01	0.007	0	43.4	38.7	74	135	121	0	34	31
2015	7	5	5	23	6	0.748	-0.072	3.862	0.013	0.01	0	43.9	38.3	73.1	136	121	0	34	32
2015	7	5	5	33	6	0.794	-0.092	3.862	0.01	0.007	0	43.9	39.1	72.7	136	122	0	34	31
2015	7	5	5	43	6	0.748	-0.112	3.862	0.01	0.007	0	43.9	38.7	72.7	136	122	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	5	5	53	6	0.787	-0.089	3.865	0.016	0.013	0	43.9	39.1	73.1	136	122	0	34	31
2015	7	5	6	3	6	0.771	-0.082	3.865	0.01	0.007	0	44.3	38.7	72.2	136	121	0	33	31
2015	7	5	6	13	6	0.778	-0.102	3.868	0.01	0.007	0	43.9	38.7	72.2	136	121	0	34	31
2015	7	5	6	23	6	0.761	-0.115	3.868	0.01	0.007	0	43.9	39.1	73.1	136	122	0	34	31
2015	7	5	6	33	6	0.784	-0.075	3.875	0.016	0.016	0	43.9	38.7	73.5	136	122	0	34	32
2015	7	5	6	43	6	0.751	-0.075	3.875	0.016	0.013	0	43.9	38.7	73.1	136	122	0	34	32
2015	7	5	6	53	6	0.768	-0.082	3.875	0.016	0.013	0	43.9	39.1	74	136	122	0	34	31
2015	7	5	7	3	6	0.764	-0.082	3.875	0.016	0.013	0	43.9	39.1	74	136	122	0	34	31
2015	7	5	7	13	6	0.794	-0.095	3.878	0.016	0.013	0	43.9	38.7	74.4	136	122	0	34	32
2015	7	5	7	23	6	0.787	-0.089	3.878	0.01	0.007	0	43.9	38.7	74.8	136	122	0	34	32
2015	7	5	7	33	6	0.735	-0.098	3.878	0.013	0.01	0	44.3	39.6	74.4	137	124	0	34	32
2015	7	5	7	43	6	0.778	-0.079	3.878	0.01	0.007	0	44.3	39.6	74.8	137	123	0	34	31
2015	7	5	7	53	6	0.758	-0.085	3.878	0.016	0.013	0	43.9	39.1	75.3	137	123	0	35	32
2015	7	5	8	3	6	0.771	-0.092	3.878	0.01	0.007	0	43.9	39.1	75.3	136	122	0	34	31
2015	7	5	8	13	6	0.732	-0.056	3.878	0.01	0.007	0	44.3	40	74	137	124	0	34	31
2015	7	5	8	23	6	0.709	-0.082	3.878	0.01	0.007	0	44.3	39.1	75.3	137	123	0	34	32
2015	7	5	8	33	6	0.778	-0.075	3.878	0.01	0.007	0	43.9	39.1	75.7	137	123	0	35	32
2015	7	5	8	43	6	0.755	-0.095	3.878	0.013	0.01	0	44.3	39.6	75.3	136	123	0	33	31
2015	7	5	8	53	6	0.774	-0.112	3.878	0.01	0.007	0	44.3	39.6	74.8	137	123	0	34	31
2015	7	5	9	3	6	0.732	-0.066	3.878	0.01	0.007	0	44.3	39.6	75.3	137	124	0	34	32
2015	7	5	9	13	6	0.771	-0.082	3.878	0.01	0.007	0	44.7	39.6	74.4	137	123	0	33	31
2015	7	5	9	23	6	0.787	-0.118	3.878	0.01	0.007	0	44.7	40	74.8	138	124	0	34	31
2015	7	5	9	33	6	0.774	-0.125	3.878	0.013	0.01	0	44.7	40	74	137	124	0	33	31
2015	7	5	9	43	6	0.764	-0.062	3.878	0.016	0.013	0	44.3	39.1	74.8	137	123	0	34	32
2015	7	5	9	53	6	0.761	-0.102	3.878	0.013	0.01	0	44.3	39.1	74	137	123	0	34	32
2015	7	5	10	3	6	0.764	-0.098	3.878	0.013	0.01	0	44.7	40.4	73.5	138	124	0	34	30
2015	7	5	10	13	6	0.771	-0.089	3.878	0.013	0.01	0	43.9	39.6	73.5	136	123	0	34	31
2015	7	5	10	23	6	0.755	-0.125	3.878	0.013	0.01	0	43.4	39.1	73.5	135	122	0	34	31
2015	7	5	10	33	6	0.758	-0.115	3.878	0.013	0.01	0	43.4	38.7	74	135	121	0	34	31
2015	7	5	10	43	6	0.748	-0.112	3.878	0.01	0.007	0	43	39.1	74.4	135	122	0	35	31
2015	7	5	10	53	6	0.738	-0.082	3.878	0.013	0.01	0	43.4	39.1	73.1	135	122	0	34	31
2015	7	5	11	3	6	0.732	-0.072	3.878	0.013	0.01	0	43.9	38.7	72.2	136	122	0	34	32
2015	7	5	11	13	6	0.751	-0.082	3.878	0.013	0.01	0	43.4	39.1	72.2	136	122	0	35	31
2015	7	5	11	23	6	0.732	-0.102	3.875	0.01	0.007	0	43.4	39.1	72.2	135	122	0	34	31
2015	7	5	11	33	6	0.735	-0.085	3.871	0.016	0.013	0	43.9	39.6	70.1	136	123	0	34	31
2015	7	5	11	43	6	0.732	-0.082	3.868	0.016	0.013	0	43.9	39.6	66.2	136	123	0	34	31
2015	7	5	11	53	6	0.705	-0.105	3.868	0.02	0.016	0	43.9	39.1	58.5	136	123	0	34	32
2015	7	5	12	3	6	0.722	-0.052	3.865	0.01	0.007	0	43.9	39.6	58	136	123	0	34	31
2015	7	5	12	13	6	0.745	-0.092	3.865	0.01	0.007	0	43.9	39.1	63.6	136	122	0	34	31
2015	7	5	12	23	6	0.758	-0.075	3.865	0.013	0.01	0	43	39.1	67.9	135	122	0	35	31
2015	7	5	12	33	6	0.702	-0.102	3.865	0.01	0.007	0	43.9	39.1	66.7	136	122	0	34	31
2015	7	5	12	43	6	0.732	-0.079	3.865	0.013	0.01	0	43.9	38.7	54.6	136	122	0	34	32
2015	7	5	12	53	6	0.748	-0.082	3.865	0.01	0.007	0	43.4	38.7	55.5	135	122	0	34	32
2015	7	5	13	3	6	0.725	-0.102	3.862	0.01	0.007	0	43	38.7	55.5	134	121	0	34	31
2015	7	5	13	13	6	0.722	-0.105	3.862	0.01	0.007	0	43	38.3	62.4	134	120	0	34	31
2015	7	5	13	23	6	0.774	-0.085	3.862	0.01	0.007	0	43	37.8	67.5	134	120	0	34	32
2015	7	5	13	33	6	0.728	-0.121	3.862	0.01	0.007	0	42.6	38.3	60.6	133	120	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	5	13	43	6	0.722	-0.089	3.858	0.016	0.013	0	42.6	37.8	55.5	133	120	0	34	32
2015	7	5	13	53	6	0.715	-0.072	3.858	0.016	0.013	0	43	38.3	68.4	134	120	0	34	31
2015	7	5	14	3	6	0.732	-0.095	3.858	0.01	0.007	0	43	38.3	65.4	134	121	0	34	32
2015	7	5	14	13	6	0.784	-0.082	3.862	0.013	0.01	0	43	37.8	74.8	134	120	0	34	32
2015	7	5	14	23	6	0.738	-0.069	3.862	0.01	0.007	0	43.9	39.6	61.9	137	123	0	35	31
2015	7	5	14	33	6	0.728	-0.121	3.858	0.013	0.01	0	43.4	38.3	71.4	134	120	0	33	31
2015	7	5	14	43	6	0.755	-0.082	3.858	0.013	0.01	0	43.4	37.8	68.4	135	120	0	34	32
2015	7	5	14	53	6	0.725	-0.092	3.858	0.013	0.01	0	44.3	40	64.5	137	124	0	34	31
2015	7	5	15	3	6	0.745	-0.052	3.858	0.013	0.01	0	45.2	40	57.6	139	125	0	34	32
2015	7	5	15	13	6	0.748	-0.079	3.858	0.01	0.007	0	44.7	40.4	65.4	138	125	0	34	31
2015	7	5	15	23	6	0.761	-0.062	3.858	0.013	0.01	0	44.3	39.6	65.4	137	123	0	34	31
2015	7	5	15	33	6	0.764	-0.075	3.858	0.01	0.007	0	44.3	39.1	64.5	137	123	0	34	32
2015	7	5	15	43	6	0.735	-0.082	3.858	0.016	0.013	0	44.3	39.6	70.5	136	123	0	33	31
2015	7	5	15	53	6	0.764	-0.062	3.858	0.013	0.01	0	47.3	42.1	48.6	143	129	0	33	31
2015	7	5	16	3	6	0.722	-0.046	3.855	0.013	0.01	0	49	44.3	42.6	148	135	0	34	32
2015	7	5	16	13	6	0.764	-0.079	3.855	0.01	0.007	0	46.4	41.7	44.7	142	128	0	34	31
2015	7	5	16	23	6	0.751	-0.052	3.855	0.013	0.01	0	49.9	45.6	43	150	137	0	34	31
2015	7	5	16	33	6	0.768	-0.069	3.855	0.01	0.007	0	51.2	46.9	42.1	153	141	0	34	32
2015	7	5	16	43	6	0.735	-0.092	3.855	0.01	0.007	0	38.3	47.3	41.7	123	142	0	34	32
2015	7	5	16	53	6	0.728	-0.049	3.852	0.013	0.01	0	49.5	45.6	45.6	149	137	0	34	31
2015	7	5	17	3	6	0.764	-0.112	3.858	0.016	0.013	0	48.2	43	46	145	131	0	33	31
2015	7	5	17	13	6	0.712	-0.046	3.855	0.01	0.007	0	48.6	46	46	146	138	0	33	31
2015	7	5	17	23	6	0.728	-0.069	3.855	0.013	0.01	0	49.9	45.2	43.4	150	136	0	34	31
2015	7	5	17	33	6	0.817	-0.085	3.858	0.013	0.01	0	43.9	39.6	48.2	135	123	0	33	31
2015	7	5	17	43	6	0.715	-0.082	3.855	0.013	0.01	0	46	40.9	46.4	140	127	0	33	32
2015	7	5	17	53	6	0.751	-0.049	3.858	0.016	0.013	0	46.4	42.6	43.4	142	130	0	34	31
2015	7	5	18	3	6	0.784	-0.092	3.855	0.013	0.01	0	45.2	40.9	52	139	126	0	34	31
2015	7	5	18	13	6	0.787	-0.062	3.858	0.013	0.01	0	46	42.1	47.7	141	129	0	34	31
2015	7	5	18	23	6	0.761	-0.056	3.858	0.01	0.007	0	46.4	42.1	48.6	142	129	0	34	31
2015	7	5	18	33	6	0.715	-0.069	3.858	0.01	0.007	0	44.7	40.4	64.9	138	125	0	34	31
2015	7	5	18	43	6	0.761	-0.079	3.858	0.01	0.007	0	43.9	40	55.5	136	124	0	34	31
2015	7	5	18	53	6	0.715	-0.082	3.858	0.01	0.007	0	44.3	40.4	55.9	137	125	0	34	31
2015	7	5	19	3	6	0.761	-0.079	3.858	0.01	0.007	0	44.7	40	56.3	137	124	0	33	31
2015	7	5	19	13	6	0.715	-0.098	3.858	0.013	0.01	0	45.2	40.9	58	139	126	0	34	31
2015	7	5	19	23	6	0.761	-0.075	3.858	0.013	0.01	0	44.3	40	71.8	137	124	0	34	31
2015	7	5	19	33	6	0.764	-0.112	3.858	0.01	0.007	0	43	38.7	66.2	134	122	0	34	32
2015	7	5	19	43	6	0.741	-0.098	3.858	0.013	0.01	0	43	38.7	74.8	134	121	0	34	31
2015	7	5	19	53	6	0.715	-0.059	3.858	0.01	0.007	0	43.4	38.3	74.8	134	120	0	33	31
2015	7	5	20	3	6	0.774	-0.069	3.858	0.01	0.007	0	42.6	38.3	75.7	133	120	0	34	31
2015	7	5	20	13	6	0.745	-0.069	3.858	0.013	0.01	0	42.6	37.8	75.7	133	120	0	34	32
2015	7	5	20	23	6	0.791	-0.115	3.858	0.01	0.007	0	43	38.7	75.3	134	121	0	34	31
2015	7	5	20	33	6	0.761	-0.085	3.858	0.013	0.01	0	43.9	40	75.3	136	124	0	34	31
2015	7	5	20	43	6	0.778	-0.105	3.858	0.01	0.007	0	44.3	40.4	74	137	125	0	34	31
2015	7	5	20	53	6	0.745	-0.072	3.862	0.01	0.007	0	44.7	40	74	137	125	0	33	32
2015	7	5	21	3	6	0.751	-0.102	3.862	0.013	0.01	0	43.9	39.6	74.4	136	124	0	34	32
2015	7	5	21	13	6	0.771	-0.082	3.862	0.01	0.007	0	43.9	40	72.7	136	124	0	34	31
2015	7	5	21	23	6	0.787	-0.082	3.862	0.013	0.01	0	43.4	39.6	74	135	123	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	5	21	33	6	0.755	-0.056	3.862	0.01	0.007	0	43.4	39.6	74.8	135	123	0	34	31
2015	7	5	21	43	6	0.738	-0.082	3.862	0.013	0.01	0	43.4	39.6	74.8	135	123	0	34	31
2015	7	5	21	53	6	0.768	-0.085	3.862	0.01	0.007	0	43	39.1	74	134	122	0	34	31
2015	7	5	22	3	6	0.791	-0.098	3.862	0.016	0.013	0	43	39.1	73.5	134	122	0	34	31
2015	7	5	22	13	6	0.81	-0.112	3.862	0.013	0.01	0	43.4	39.6	73.1	135	123	0	34	31
2015	7	5	22	23	6	0.784	-0.085	3.862	0.016	0.013	0	43.4	39.1	73.1	135	122	0	34	31
2015	7	5	22	33	6	0.741	-0.108	3.862	0.013	0.01	0	43.4	38.7	73.1	135	122	0	34	32
2015	7	5	22	43	6	0.761	-0.118	3.865	0.013	0.01	0	43.4	38.7	73.5	135	122	0	34	32
2015	7	5	22	53	6	0.728	-0.082	3.865	0.013	0.01	0	43.4	39.6	72.2	135	123	0	34	31
2015	7	5	23	3	6	0.761	-0.082	3.865	0.013	0.01	0	43.4	39.1	72.7	135	122	0	34	31
2015	7	5	23	13	6	0.755	-0.095	3.865	0.013	0.01	0	43.4	39.1	73.1	135	122	0	34	31
2015	7	5	23	23	6	0.738	-0.112	3.868	0.016	0.013	0	43.4	39.6	72.7	135	123	0	34	31
2015	7	5	23	33	6	0.738	-0.082	3.871	0.013	0.01	0	43.4	39.1	72.7	135	123	0	34	32
2015	7	5	23	43	6	0.745	-0.102	3.875	0.013	0.01	0	43.4	38.7	71.8	135	122	0	34	32
2015	7	5	23	53	6	0.758	-0.098	3.875	0.01	0.007	0	43.9	39.1	72.7	135	122	0	33	31
2015	7	6	0	3	6	0.741	-0.121	3.878	0.01	0.007	0	43.4	39.6	72.2	135	123	0	34	31
2015	7	6	0	13	6	0.758	-0.098	3.878	0.013	0.01	0	43.4	39.1	73.5	135	123	0	34	32
2015	7	6	0	23	6	0.735	-0.085	3.878	0.01	0.007	0	43.4	39.1	73.1	135	123	0	34	32
2015	7	6	0	33	6	0.758	-0.098	3.878	0.01	0.007	0	42.6	38.3	74	133	120	0	34	31
2015	7	6	0	43	6	0.83	-0.056	3.881	0.01	0.007	0	42.6	37.8	74	133	120	0	34	32
2015	7	6	0	53	6	0.764	-0.121	3.881	0.013	0.01	0	43	37.8	74.4	133	120	0	33	32
2015	7	6	1	3	6	0.787	-0.049	3.881	0.01	0.007	0	42.6	37.8	74	133	120	0	34	32
2015	7	6	1	13	6	0.725	-0.075	3.881	0.013	0.01	0	42.6	38.3	74.4	133	120	0	34	31
2015	7	6	1	23	6	0.741	-0.092	3.881	0.013	0.01	0	42.6	38.3	74.8	133	120	0	34	31
2015	7	6	1	33	6	0.768	-0.115	3.881	0.01	0.007	0	43.4	39.1	75.3	134	122	0	33	31
2015	7	6	1	43	6	0.781	-0.062	3.881	0.01	0.007	0	43	38.7	75.7	134	121	0	34	31
2015	7	6	1	53	6	0.751	-0.082	3.885	0.013	0.01	0	43	39.1	74.8	134	122	0	34	31
2015	7	6	2	3	6	0.751	-0.102	3.885	0.01	0.007	0	43	38.3	76.5	134	121	0	34	32
2015	7	6	2	13	6	0.791	-0.079	3.885	0.013	0.01	0	42.6	38.3	76.5	133	120	0	34	31
2015	7	6	2	23	6	0.768	-0.075	3.885	0.01	0.007	0	42.6	38.3	76.1	133	120	0	34	31
2015	7	6	2	33	6	0.774	-0.085	3.885	0.01	0.007	0	43.4	39.6	75.7	135	123	0	34	31
2015	7	6	2	43	6	0.751	-0.085	3.885	0.01	0.007	0	43.9	40	75.7	136	124	0	34	31
2015	7	6	2	53	6	0.801	-0.079	3.885	0.01	0.007	0	43.9	40	76.5	136	124	0	34	31
2015	7	6	3	3	6	0.738	-0.102	3.885	0.01	0.007	0	43.9	39.6	75.3	136	124	0	34	32
2015	7	6	3	13	6	0.771	-0.089	3.885	0.01	0.007	0	43.9	40	76.5	136	124	0	34	31
2015	7	6	3	23	6	0.764	-0.082	3.885	0.016	0.013	0	43.9	40	76.5	136	124	0	34	31
2015	7	6	3	33	6	0.768	-0.075	3.885	0.01	0.007	0	43.4	39.6	76.1	135	123	0	34	31
2015	7	6	3	43	6	0.774	-0.056	3.888	0.01	0.007	0	44.3	40	76.5	137	124	0	34	31
2015	7	6	3	53	6	0.755	-0.082	3.885	0.01	0.007	0	44.3	39.6	76.1	136	124	0	33	32
2015	7	6	4	3	6	0.771	-0.098	3.885	0.01	0.007	0	44.3	39.6	76.5	137	124	0	34	32
2015	7	6	4	13	6	0.745	-0.092	3.888	0.01	0.007	0	44.3	40	75.7	137	125	0	34	32
2015	7	6	4	23	6	0.823	-0.082	3.885	0.01	0.007	0	44.3	40	76.5	136	124	0	33	31
2015	7	6	4	33	6	0.738	-0.115	3.888	0.013	0.01	0	43.4	40	76.1	136	124	0	35	31
2015	7	6	4	43	6	0.774	-0.089	3.885	0.013	0.01	0	43.9	40	75.3	136	124	0	34	31
2015	7	6	4	53	6	0.755	-0.082	3.888	0.016	0.013	0	44.3	40	75.3	137	125	0	34	32
2015	7	6	5	3	6	0.771	-0.079	3.885	0.01	0.007	0	44.7	40	76.1	138	125	0	34	32
2015	7	6	5	13	6	0.781	-0.062	3.885	0.01	0.007	0	44.3	40.4	76.1	137	125	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	6	5	23	6	0.797	-0.066	3.885	0.013	0.01	0	45.6	40.4	74.4	140	126	0	34	32
2015	7	6	5	33	6	0.787	-0.092	3.885	0.01	0.007	0	45.2	40.4	76.1	139	126	0	34	32
2015	7	6	5	43	6	0.784	-0.092	3.888	0.01	0.007	0	44.7	40.9	75.7	139	126	0	35	31
2015	7	6	5	53	6	0.748	-0.089	3.885	0.013	0.01	0	45.6	40.4	75.3	140	126	0	34	32
2015	7	6	6	3	6	0.755	-0.072	3.885	0.016	0.013	0	45.6	40.9	75.7	140	126	0	34	31
2015	7	6	6	13	6	0.768	-0.131	3.885	0.01	0.007	0	45.6	40.9	75.7	140	126	0	34	31
2015	7	6	6	23	6	0.771	-0.066	3.885	0.016	0.013	0	45.2	40.4	74.4	139	125	0	34	31
2015	7	6	6	33	6	0.745	-0.059	3.888	0.01	0.007	0	45.2	40.9	75.7	139	126	0	34	31
2015	7	6	6	43	6	0.758	-0.079	3.888	0.016	0.013	0	44.7	40.4	75.7	138	125	0	34	31
2015	7	6	6	53	6	0.771	-0.112	3.888	0.01	0.007	0	44.3	39.6	75.7	138	124	0	35	32
2015	7	6	7	3	6	0.751	-0.079	3.888	0.01	0.007	0	44.3	39.6	75.7	137	124	0	34	32
2015	7	6	7	13	6	0.774	-0.095	3.888	0.01	0.007	0	44.3	39.6	75.3	137	124	0	34	32
2015	7	6	7	23	6	0.755	-0.102	3.888	0.013	0.01	0	44.3	40	75.3	137	124	0	34	31
2015	7	6	7	33	6	0.758	-0.095	3.888	0.01	0.007	0	44.3	40	75.3	137	124	0	34	31
2015	7	6	7	43	6	0.764	-0.066	3.888	0.016	0.013	0	44.3	39.6	75.3	137	124	0	34	32
2015	7	6	7	53	6	0.761	-0.075	3.888	0.01	0.007	0	44.3	40	75.7	137	125	0	34	32
2015	7	6	8	3	6	0.748	-0.079	3.888	0.016	0.013	0	44.7	40	74.8	138	124	0	34	31
2015	7	6	8	13	6	0.745	-0.098	3.888	0.01	0.007	0	44.7	39.6	75.3	138	124	0	34	32
2015	7	6	8	23	6	0.791	-0.079	3.888	0.013	0.01	0	44.3	40	75.3	137	124	0	34	31
2015	7	6	8	33	6	0.771	-0.066	3.888	0.01	0.007	0	44.7	40	75.3	138	125	0	34	32
2015	7	6	8	43	6	0.768	-0.085	3.888	0.016	0.013	0	44.7	40.4	75.7	138	126	0	34	32
2015	7	6	8	53	6	0.738	-0.102	3.888	0.01	0.007	0	45.2	40.9	75.3	139	126	0	34	31
2015	7	6	9	3	6	0.797	-0.121	3.888	0.01	0.007	0	44.7	40.9	75.3	138	126	0	34	31
2015	7	6	9	13	6	0.755	-0.069	3.888	0.01	0.007	0	44.7	40.4	75.3	138	126	0	34	32
2015	7	6	9	23	6	0.735	-0.082	3.888	0.016	0.013	0	45.2	40.9	75.3	139	127	0	34	32
2015	7	6	9	33	6	0.758	-0.089	3.888	0.01	0.007	0	44.3	40.4	75.7	138	126	0	35	32
2015	7	6	9	43	6	0.738	-0.085	3.888	0.016	0.013	0	45.2	40.4	75.3	139	126	0	34	32
2015	7	6	9	53	6	0.732	-0.082	3.888	0.01	0.007	0	45.2	40	75.3	138	125	0	33	32
2015	7	6	10	3	6	0.764	-0.072	3.888	0.013	0.01	0	44.3	40	75.3	137	124	0	34	31
2015	7	6	10	13	6	0.725	-0.079	3.888	0.016	0.013	0	44.7	40.4	74.8	138	125	0	34	31
2015	7	6	10	23	6	0.801	-0.085	3.888	0.01	0.007	0	44.7	40	75.7	138	124	0	34	31
2015	7	6	10	33	6	0.761	-0.102	3.888	0.013	0.01	0	44.3	40.4	75.7	137	125	0	34	31
2015	7	6	10	43	6	0.748	-0.079	3.888	0.013	0.01	0	44.3	40	75.7	137	124	0	34	31
2015	7	6	10	53	6	0.741	-0.105	3.888	0.01	0.007	0	44.3	39.6	74.4	137	124	0	34	32
2015	7	6	11	3	6	0.758	-0.062	3.888	0.01	0.007	0	44.3	40	75.7	137	124	0	34	31
2015	7	6	11	13	6	0.784	-0.102	3.888	0.01	0.007	0	43.9	39.1	75.7	136	123	0	34	32
2015	7	6	11	23	6	0.774	-0.115	3.888	0.013	0.01	0	43.9	39.6	75.3	136	123	0	34	31
2015	7	6	11	33	6	0.722	-0.082	3.888	0.01	0.007	0	44.3	40.4	63.2	137	125	0	34	31
2015	7	6	11	43	6	0.768	-0.069	3.888	0.01	0.007	0	44.3	39.6	62.4	137	124	0	34	32
2015	7	6	11	53	6	0.709	-0.069	3.888	0.01	0.007	0	44.3	40.4	57.6	137	125	0	34	31
2015	7	6	12	3	6	0.709	-0.102	3.888	0.01	0.007	0	44.3	39.6	61.5	137	124	0	34	32
2015	7	6	12	13	6	0.735	-0.108	3.888	0.013	0.01	0	44.7	40	58.9	138	125	0	34	32
2015	7	6	12	23	6	0.761	-0.131	3.888	0.01	0.007	0	44.3	39.6	64.9	137	124	0	34	32
2015	7	6	12	33	6	0.719	-0.108	3.888	0.01	0.007	0	44.7	40.4	61.9	138	125	0	34	31
2015	7	6	12	43	6	0.722	-0.115	3.888	0.01	0.007	0	44.3	40	64.1	137	124	0	34	31
2015	7	6	12	53	6	0.728	-0.092	3.888	0.016	0.013	0	44.3	40	61.1	137	124	0	34	31
2015	7	6	13	3	6	0.748	-0.095	3.888	0.016	0.013	0	43.9	40	57.2	137	124	0	35	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	6	13	13	6	0.738	-0.115	3.888	0.01	0.007	0	43.4	39.1	57.6	135	122	0	34	31
2015	7	6	13	23	6	0.705	-0.102	3.888	0.013	0.01	0	44.3	40	59.8	137	124	0	34	31
2015	7	6	13	33	6	0.755	-0.102	3.888	0.013	0.01	0	43.9	39.1	58.5	136	123	0	34	32
2015	7	6	13	43	6	0.764	-0.098	3.888	0.01	0.007	0	43.9	39.6	64.5	136	124	0	34	32
2015	7	6	13	53	6	0.768	-0.098	3.888	0.01	0.007	0	43.9	39.6	60.6	136	123	0	34	31
2015	7	6	14	3	6	0.751	-0.085	3.888	0.01	0.007	0	43.9	39.6	64.5	136	123	0	34	31
2015	7	6	14	13	6	0.784	-0.075	3.888	0.013	0.01	0	43.9	40	57.6	136	124	0	34	31
2015	7	6	14	23	6	0.699	-0.089	3.888	0.01	0.007	0	43.4	40	54.2	136	124	0	35	31
2015	7	6	14	33	6	0.774	-0.098	3.885	0.01	0.007	0	43.4	39.6	59.3	136	124	0	35	32
2015	7	6	14	43	6	0.761	-0.082	3.885	0.016	0.013	0	44.3	39.6	63.6	137	124	0	34	32
2015	7	6	14	53	6	0.755	-0.062	3.885	0.013	0.01	0	43.4	39.1	59.8	136	123	0	35	32
2015	7	6	15	3	6	0.755	-0.089	3.885	0.01	0.007	0	44.3	39.6	55.9	137	124	0	34	32
2015	7	6	15	13	6	0.732	-0.082	3.885	0.01	0.007	0	43.4	39.1	55.9	135	122	0	34	31
2015	7	6	15	23	6	0.764	-0.079	3.885	0.01	0.007	0	43.4	38.7	53.3	134	121	0	33	31
2015	7	6	15	33	6	0.745	-0.082	3.885	0.01	0.007	0	42.6	38.3	61.1	133	120	0	34	31
2015	7	6	15	43	6	0.745	-0.108	3.885	0.01	0.007	0	42.6	38.7	64.1	134	121	0	35	31
2015	7	6	15	53	6	0.764	-0.072	3.885	0.013	0.01	0	42.6	37.8	72.2	133	120	0	34	32
2015	7	6	16	3	6	0.722	-0.102	3.885	0.01	0.007	0	43	38.7	71.8	134	121	0	34	31
2015	7	6	16	13	6	0.784	-0.098	3.885	0.016	0.013	0	42.6	38.3	74.4	133	120	0	34	31
2015	7	6	16	23	6	0.755	-0.095	3.885	0.013	0.01	0	42.6	38.3	71.4	133	121	0	34	32
2015	7	6	16	33	6	0.741	-0.118	3.885	0.013	0.01	0	43	38.7	66.7	133	121	0	33	31
2015	7	6	16	43	6	0.764	-0.082	3.885	0.013	0.01	0	43	38.7	69.7	134	121	0	34	31
2015	7	6	16	53	6	0.745	-0.092	3.885	0.013	0.01	0	43.4	39.1	73.5	135	122	0	34	31
2015	7	6	17	3	6	0.735	-0.043	3.885	0.01	0.007	0	43	38.7	76.5	134	122	0	34	32
2015	7	6	17	13	6	0.728	-0.075	3.885	0.01	0.007	0	43	38.7	76.5	134	121	0	34	31
2015	7	6	17	23	6	0.771	-0.079	3.888	0.01	0.007	0	43	38.7	76.5	134	121	0	34	31
2015	7	6	17	33	6	0.748	-0.095	3.888	0.013	0.01	0	43.4	39.1	77	135	122	0	34	31
2015	7	6	17	43	6	0.774	-0.092	3.888	0.01	0.007	0	43.4	38.7	77	135	122	0	34	32
2015	7	6	17	53	6	0.807	-0.095	3.888	0.01	0.007	0	43.4	39.1	76.5	135	122	0	34	31
2015	7	6	18	3	6	0.784	-0.092	3.888	0.013	0.01	0	43.9	39.1	77	136	122	0	34	31
2015	7	6	18	13	6	0.748	-0.082	3.888	0.01	0.007	0	43.9	39.1	76.5	136	122	0	34	31
2015	7	6	18	23	6	0.764	-0.066	3.888	0.01	0.007	0	44.3	39.1	76.5	137	123	0	34	32
2015	7	6	18	33	6	0.751	-0.098	3.888	0.016	0.016	0	43.9	39.6	77	136	123	0	34	31
2015	7	6	18	43	6	0.735	-0.082	3.888	0.01	0.007	0	44.3	39.6	76.5	137	123	0	34	31
2015	7	6	18	53	6	0.781	-0.089	3.888	0.016	0.013	0	43.9	39.6	77	136	123	0	34	31
2015	7	6	19	3	6	0.774	-0.075	3.888	0.01	0.007	0	46	40.9	68.4	140	126	0	33	31
2015	7	6	19	13	6	0.768	-0.059	3.888	0.016	0.013	0	45.2	40	68.4	138	124	0	33	31
2015	7	6	19	23	6	0.784	-0.115	3.888	0.01	0.007	0	44.7	40.4	63.6	138	125	0	34	31
2015	7	6	19	33	6	0.764	-0.082	3.888	0.013	0.01	0	44.3	39.1	76.1	137	123	0	34	32
2015	7	6	19	43	6	0.791	-0.085	3.891	0.01	0.007	0	43.9	38.7	77	136	122	0	34	32
2015	7	6	19	53	6	0.748	-0.095	3.891	0.016	0.013	0	43.9	39.6	77	136	123	0	34	31
2015	7	6	20	3	6	0.781	-0.128	3.891	0.016	0.013	0	43.9	38.7	76.1	136	122	0	34	32
2015	7	6	20	13	6	0.738	-0.079	3.891	0.01	0.007	0	43.9	39.6	76.1	136	123	0	34	31
2015	7	6	20	23	6	0.764	-0.089	3.891	0.016	0.016	0	43.9	39.6	76.5	136	123	0	34	31
2015	7	6	20	33	6	0.778	-0.036	3.891	0.01	0.007	0	44.3	40	75.7	137	124	0	34	31
2015	7	6	20	43	6	0.732	-0.082	3.891	0.01	0.007	0	44.3	39.6	74.8	137	123	0	34	31
2015	7	6	20	53	6	0.771	-0.095	3.891	0.013	0.01	0	44.7	39.6	74.8	138	124	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	6	21	3	6	0.758	-0.049	3.891	0.01	0.007	0	45.2	40	75.3	138	125	0	33	32
2015	7	6	21	13	6	0.761	-0.108	3.891	0.01	0.007	0	44.7	40.4	74.8	138	125	0	34	31
2015	7	6	21	23	6	0.778	-0.098	3.891	0.013	0.01	0	44.7	40	72.7	138	124	0	34	31
2015	7	6	21	33	6	0.833	-0.062	3.891	0.01	0.007	0	44.7	40	71.8	138	124	0	34	31
2015	7	6	21	43	6	0.778	-0.069	3.891	0.013	0.01	0	44.3	40	74	138	124	0	35	31
2015	7	6	21	53	6	0.732	-0.082	3.894	0.013	0.01	0	44.7	39.6	69.2	138	124	0	34	32
2015	7	6	22	3	6	0.745	-0.052	3.894	0.013	0.01	0	44.3	39.1	74.4	137	123	0	34	32
2015	7	6	22	13	6	0.787	-0.072	3.894	0.01	0.007	0	44.7	40	74.4	138	124	0	34	31
2015	7	6	22	23	6	0.745	-0.082	3.894	0.01	0.007	0	44.3	39.1	74.4	137	123	0	34	32
2015	7	6	22	33	6	0.751	-0.049	3.894	0.013	0.01	0	44.7	39.6	74.4	137	123	0	33	31
2015	7	6	22	43	6	0.751	-0.049	3.894	0.01	0.007	0	43.9	39.6	74.4	136	123	0	34	31
2015	7	6	22	53	6	0.748	-0.105	3.898	0.013	0.01	0	43.9	39.6	74.8	136	123	0	34	31
2015	7	6	23	3	6	0.751	-0.092	3.898	0.013	0.01	0	43.9	39.6	73.1	136	123	0	34	31
2015	7	6	23	13	6	0.741	-0.098	3.898	0.013	0.01	0	43.9	39.1	74	136	122	0	34	31
2015	7	6	23	23	6	0.791	-0.066	3.898	0.01	0.007	0	43.9	39.1	74.8	136	123	0	34	32
2015	7	6	23	33	6	0.748	-0.095	3.898	0.013	0.01	0	44.7	39.1	74	137	123	0	33	32
2015	7	6	23	43	6	0.787	-0.082	3.898	0.013	0.01	0	44.3	39.6	74	136	123	0	33	31
2015	7	6	23	53	6	0.784	-0.092	3.901	0.01	0.007	0	44.7	39.1	73.5	137	123	0	33	32
2015	7	7	0	3	6	0.797	-0.072	3.901	0.013	0.01	0	43.9	39.1	73.1	136	123	0	34	32
2015	7	7	0	13	6	0.791	-0.105	3.901	0.013	0.01	0	43.9	38.7	72.2	136	122	0	34	32
2015	7	7	0	23	6	0.755	-0.105	3.901	0.013	0.01	0	44.3	39.6	71.4	137	123	0	34	31
2015	7	7	0	33	6	0.791	-0.056	3.904	0.013	0.01	0	44.3	39.6	72.7	137	123	0	34	31
2015	7	7	0	43	6	0.791	-0.085	3.907	0.013	0.01	0	44.3	39.6	71.4	137	123	0	34	31
2015	7	7	0	53	6	0.761	-0.066	3.911	0.013	0.01	0	43.9	38.7	72.7	136	122	0	34	32
2015	7	7	1	3	6	0.735	-0.075	3.914	0.01	0.007	0	43.9	38.7	72.2	136	122	0	34	32
2015	7	7	1	13	6	0.791	-0.069	3.917	0.01	0.007	0	43.9	39.1	72.7	136	122	0	34	31
2015	7	7	1	23	6	0.761	-0.098	3.917	0.013	0.01	0	43.9	39.1	73.5	136	123	0	34	32
2015	7	7	1	33	6	0.774	-0.098	3.917	0.013	0.01	0	44.3	39.6	74.4	137	124	0	34	32
2015	7	7	1	43	6	0.82	-0.082	3.917	0.013	0.01	0	44.3	39.6	74.4	137	123	0	34	31
2015	7	7	1	53	6	0.774	-0.082	3.921	0.013	0.01	0	43.9	39.1	74.8	136	122	0	34	31
2015	7	7	2	3	6	0.761	-0.075	3.921	0.013	0.01	0	44.3	39.6	74	137	123	0	34	31
2015	7	7	2	13	6	0.823	-0.066	3.921	0.01	0.007	0	43.9	38.7	76.1	136	122	0	34	32
2015	7	7	2	23	6	0.738	-0.072	3.924	0.01	0.007	0	44.3	39.1	75.7	137	123	0	34	32
2015	7	7	2	33	6	0.774	-0.085	3.924	0.013	0.01	0	43.9	39.1	76.5	136	122	0	34	31
2015	7	7	2	43	6	0.791	-0.085	3.924	0.013	0.01	0	43.4	39.6	76.5	136	123	0	35	31
2015	7	7	2	53	6	0.781	-0.105	3.924	0.01	0.007	0	44.3	39.1	76.1	137	123	0	34	32
2015	7	7	3	3	6	0.755	-0.062	3.927	0.01	0.007	0	44.3	39.6	77	137	123	0	34	31
2015	7	7	3	13	6	0.787	-0.098	3.927	0.013	0.01	0	44.3	39.1	77	137	123	0	34	32
2015	7	7	3	23	6	0.751	-0.052	3.927	0.01	0.007	0	44.3	39.6	76.1	137	124	0	34	32
2015	7	7	3	33	6	0.807	-0.075	3.927	0.01	0.007	0	44.3	39.6	76.5	137	124	0	34	32
2015	7	7	3	43	6	0.758	-0.082	3.927	0.01	0.007	0	44.7	39.6	76.1	137	123	0	33	31
2015	7	7	3	53	6	0.804	-0.089	3.927	0.01	0.007	0	44.3	39.6	75.7	137	123	0	34	31
2015	7	7	4	3	6	0.807	-0.102	3.927	0.013	0.01	0	44.7	39.6	76.5	138	124	0	34	32
2015	7	7	4	13	6	0.761	-0.085	3.93	0.013	0.01	0	44.7	40	75.7	138	124	0	34	31
2015	7	7	4	23	6	0.735	-0.052	3.93	0.01	0.007	0	45.2	40	76.1	138	124	0	33	31
2015	7	7	4	33	6	0.725	-0.069	3.93	0.013	0.01	0	44.7	39.6	75.3	138	124	0	34	32
2015	7	7	4	43	6	0.791	-0.082	3.93	0.01	0.007	0	44.3	40	75.3	137	124	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	7	4	53	6	0.755	-0.062	3.93	0.01	0.007	0	44.7	40	75.3	138	124	0	34	31
2015	7	7	5	3	6	0.758	-0.098	3.934	0.013	0.01	0	44.7	39.6	74	138	124	0	34	32
2015	7	7	5	13	6	0.771	-0.092	3.934	0.01	0.007	0	44.7	40.4	74.4	138	125	0	34	31
2015	7	7	5	23	6	0.741	-0.098	3.934	0.01	0.007	0	45.2	40.4	74.4	139	125	0	34	31
2015	7	7	5	33	6	0.82	-0.095	3.934	0.013	0.01	0	44.7	40.4	73.1	138	125	0	34	31
2015	7	7	5	43	6	0.791	-0.062	3.937	0.01	0.007	0	45.2	40.4	72.2	139	126	0	34	32
2015	7	7	5	53	6	0.781	-0.072	3.937	0.01	0.007	0	44.7	39.6	73.1	138	125	0	34	33
2015	7	7	6	3	6	0.771	-0.092	3.94	0.01	0.007	0	44.7	40	72.2	138	124	0	34	31
2015	7	7	6	13	6	0.755	-0.069	3.944	0.01	0.007	0	45.2	40	71.4	139	124	0	34	31
2015	7	7	6	23	6	0.751	-0.082	3.95	0.01	0.007	0	44.3	39.1	72.2	138	123	0	35	32
2015	7	7	6	33	6	0.807	-0.079	3.95	0.01	0.007	0	45.2	39.6	72.7	138	124	0	33	32
2015	7	7	6	43	6	0.791	-0.089	3.953	0.01	0.007	0	44.3	39.1	74	137	123	0	34	32
2015	7	7	6	53	6	0.738	-0.095	3.953	0.01	0.007	0	43.9	39.1	74.8	136	122	0	34	31
2015	7	7	7	3	6	0.771	-0.082	3.953	0.013	0.01	0	43.9	38.7	74.8	136	122	0	34	32
2015	7	7	7	13	6	0.771	-0.082	3.957	0.01	0.007	0	43.9	38.7	75.3	136	121	0	34	31
2015	7	7	7	23	6	0.774	-0.072	3.957	0.013	0.01	0	43.9	38.7	76.1	136	122	0	34	32
2015	7	7	7	33	6	0.771	-0.098	3.957	0.013	0.01	0	43.4	38.7	76.5	135	121	0	34	31
2015	7	7	7	43	6	0.797	-0.095	3.957	0.01	0.007	0	43.4	38.3	77	135	121	0	34	32
2015	7	7	7	53	6	0.801	-0.062	3.96	0.013	0.01	0	43.4	38.7	76.1	135	121	0	34	31
2015	7	7	8	3	6	0.784	-0.105	3.96	0.01	0.007	0	43.9	39.1	76.5	136	122	0	34	31
2015	7	7	8	13	6	0.801	-0.095	3.96	0.01	0.007	0	43.9	39.1	77	136	122	0	34	31
2015	7	7	8	23	6	0.801	-0.072	3.96	0.01	0.007	0	43.9	39.1	77	136	122	0	34	31
2015	7	7	8	33	6	0.823	-0.079	3.96	0.013	0.01	0	43.4	38.7	77	135	121	0	34	31
2015	7	7	8	43	6	0.768	-0.095	3.963	0.016	0.013	0	43.9	38.7	77	136	122	0	34	32
2015	7	7	8	53	6	0.791	-0.082	3.963	0.016	0.013	0	43.4	38.7	77	135	121	0	34	31
2015	7	7	9	3	6	0.778	-0.098	3.963	0.01	0.007	0	43.4	39.1	76.5	135	122	0	34	31
2015	7	7	9	13	6	0.794	-0.069	3.963	0.01	0.007	0	43	38.3	76.5	135	121	0	35	32
2015	7	7	9	23	6	0.791	-0.066	3.963	0.01	0.007	0	43.4	37.8	76.1	135	120	0	34	32
2015	7	7	9	33	6	0.764	-0.115	3.963	0.013	0.01	0	42.1	37.8	77	133	120	0	35	32
2015	7	7	9	43	6	0.771	-0.112	3.967	0.013	0.01	0	42.6	37.4	76.5	133	119	0	34	32
2015	7	7	9	53	6	0.771	-0.082	3.967	0.01	0.007	0	42.1	37.4	75.7	132	118	0	34	31
2015	7	7	10	3	6	0.748	-0.115	3.967	0.01	0.007	0	42.6	37.8	75.7	133	119	0	34	31
2015	7	7	10	13	6	0.771	-0.115	3.967	0.01	0.007	0	42.6	38.3	75.7	133	120	0	34	31
2015	7	7	10	23	6	0.774	-0.105	3.967	0.01	0.007	0	43	37.4	75.3	133	119	0	33	32
2015	7	7	10	33	6	0.774	-0.066	3.967	0.013	0.01	0	42.6	37.4	75.7	133	119	0	34	32
2015	7	7	10	43	6	0.755	-0.098	3.967	0.01	0.007	0	42.6	37.4	71	133	119	0	34	32
2015	7	7	10	53	6	0.741	-0.069	3.967	0.01	0.007	0	42.1	37	64.1	132	118	0	34	32
2015	7	7	11	3	6	0.741	-0.095	3.97	0.01	0.007	0	42.1	37.8	60.2	133	119	0	35	31
2015	7	7	11	13	6	0.745	-0.085	3.97	0.016	0.013	0	42.6	37.8	55.9	133	120	0	34	32
2015	7	7	11	23	6	0.751	-0.082	3.967	0.013	0.01	0	43	38.3	65.4	134	120	0	34	31
2015	7	7	11	33	6	0.732	-0.112	3.97	0.01	0.007	0	43.4	38.7	53.8	135	122	0	34	32
2015	7	7	11	43	6	0.787	-0.046	3.97	0.01	0.007	0	44.3	39.6	57.2	137	123	0	34	31
2015	7	7	11	53	6	0.722	-0.072	3.973	0.01	0.007	0	45.2	40	53.3	139	125	0	34	32
2015	7	7	12	3	6	0.748	-0.095	3.973	0.016	0.013	0	44.3	40	55	137	124	0	34	31
2015	7	7	12	13	6	0.725	-0.079	3.97	0.013	0.01	0	44.3	39.6	57.6	137	123	0	34	31
2015	7	7	12	23	6	0.741	-0.085	3.973	0.013	0.01	0	44.3	40	54.2	137	124	0	34	31
2015	7	7	12	33	6	0.719	-0.092	3.973	0.01	0.007	0	44.3	40	55.5	137	124	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	7	12	43	6	0.745	-0.066	3.973	0.013	0.01	0	44.3	39.6	57.6	137	123	0	34	31
2015	7	7	12	53	6	0.751	-0.098	3.973	0.01	0.007	0	43.9	39.1	59.3	136	123	0	34	32
2015	7	7	13	3	6	0.778	-0.082	3.973	0.01	0.007	0	43.9	39.1	52.9	136	123	0	34	32
2015	7	7	13	13	6	0.758	-0.069	3.973	0.013	0.01	0	44.3	39.1	57.2	136	123	0	33	32
2015	7	7	13	23	6	0.735	-0.069	3.973	0.01	0.007	0	43.4	39.6	55	136	123	0	35	31
2015	7	7	13	33	6	0.738	-0.062	3.973	0.01	0.007	0	44.7	40.4	56.3	138	125	0	34	31
2015	7	7	13	43	6	0.778	-0.095	3.976	0.01	0.007	0	44.3	40	52.9	137	124	0	34	31
2015	7	7	13	53	6	0.741	-0.075	3.973	0.01	0.007	0	43.9	39.1	57.2	136	123	0	34	32
2015	7	7	14	3	6	0.745	-0.069	3.973	0.01	0.007	0	44.3	40	57.2	137	124	0	34	31
2015	7	7	14	13	6	0.722	-0.082	3.976	0.013	0.01	0	44.7	39.1	56.8	137	123	0	33	32
2015	7	7	14	23	6	0.709	-0.075	3.973	0.01	0.007	0	44.3	39.6	55.9	136	123	0	33	31
2015	7	7	14	33	6	0.722	-0.079	3.973	0.016	0.013	0	43.9	39.1	56.3	136	123	0	34	32
2015	7	7	14	43	6	0.712	-0.079	3.973	0.01	0.007	0	44.3	39.1	56.3	136	122	0	33	31
2015	7	7	14	53	6	0.728	-0.102	3.973	0.01	0.007	0	44.3	39.6	55.5	137	123	0	34	31
2015	7	7	15	3	6	0.728	-0.069	3.973	0.01	0.007	0	43.9	39.6	54.6	136	123	0	34	31
2015	7	7	15	13	6	0.781	-0.079	3.973	0.013	0.01	0	43.9	39.1	55.9	136	122	0	34	31
2015	7	7	15	23	6	0.761	-0.079	3.973	0.013	0.01	0	43.9	39.6	58	136	123	0	34	31
2015	7	7	15	33	6	0.728	-0.069	3.973	0.013	0.01	0	44.3	39.1	54.6	136	122	0	33	31
2015	7	7	15	43	6	0.728	-0.092	3.973	0.013	0.01	0	44.3	39.1	53.8	137	123	0	34	32
2015	7	7	15	53	6	0.778	-0.066	3.973	0.01	0.007	0	43.9	39.6	55.5	136	123	0	34	31
2015	7	7	16	3	6	0.764	-0.098	3.973	0.01	0.007	0	43.9	39.1	55	136	123	0	34	32
2015	7	7	16	13	6	0.732	-0.082	3.973	0.016	0.013	0	44.7	40	53.3	138	124	0	34	31
2015	7	7	16	23	6	0.735	-0.059	3.973	0.01	0.007	0	44.3	39.6	55.5	137	124	0	34	32
2015	7	7	16	33	6	0.728	-0.095	3.973	0.013	0.01	0	44.7	40	53.8	137	124	0	33	31
2015	7	7	16	43	6	0.761	-0.095	3.973	0.013	0.01	0	43.9	39.1	54.6	137	123	0	35	32
2015	7	7	16	53	6	0.692	-0.125	3.973	0.01	0.007	0	43.9	39.6	54.6	136	123	0	34	31
2015	7	7	17	3	6	0.748	-0.098	3.973	0.01	0.007	0	43.9	39.6	54.6	136	123	0	34	31
2015	7	7	17	13	6	0.709	-0.082	3.973	0.01	0.007	0	43.9	39.1	51.2	135	122	0	33	31
2015	7	7	17	23	6	0.745	-0.082	3.973	0.013	0.01	0	43.4	38.7	55.9	135	121	0	34	31
2015	7	7	17	33	6	0.748	-0.112	3.973	0.01	0.007	0	43	38.7	55	134	121	0	34	31
2015	7	7	17	43	6	0.748	-0.079	3.973	0.013	0.01	0	42.6	37.8	55.9	134	120	0	35	32
2015	7	7	17	53	6	0.712	-0.092	3.973	0.01	0.007	0	43	38.3	52.9	134	120	0	34	31
2015	7	7	18	3	6	0.728	-0.059	3.973	0.01	0.007	0	43.9	38.3	56.3	135	121	0	33	32
2015	7	7	18	13	6	0.784	-0.098	3.973	0.013	0.01	0	43	37.8	52.5	134	120	0	34	32
2015	7	7	18	23	6	0.722	-0.095	3.973	0.01	0.007	0	43	38.3	57.2	134	121	0	34	32
2015	7	7	18	33	6	0.761	-0.072	3.973	0.01	0.007	0	43.9	38.3	57.6	135	121	0	33	32
2015	7	7	18	43	6	0.758	-0.092	3.973	0.01	0.007	0	43.9	38.7	54.2	136	122	0	34	32
2015	7	7	18	53	6	0.725	-0.102	3.973	0.01	0.007	0	43.4	38.7	55.5	135	121	0	34	31
2015	7	7	19	3	6	0.745	-0.105	3.973	0.013	0.01	0	43	38.3	56.8	134	120	0	34	31
2015	7	7	19	13	6	0.735	-0.066	3.973	0.013	0.01	0	43.4	39.1	57.2	135	122	0	34	31
2015	7	7	19	23	6	0.764	-0.089	3.973	0.01	0.007	0	43.4	38.7	58	135	121	0	34	31
2015	7	7	19	33	6	0.755	-0.095	3.973	0.01	0.007	0	43	38.3	56.3	134	120	0	34	31
2015	7	7	19	43	6	0.712	-0.098	3.973	0.013	0.01	0	43.4	38.7	59.3	135	121	0	34	31
2015	7	7	19	53	6	0.781	-0.079	3.973	0.013	0.01	0	43.4	39.1	61.5	135	122	0	34	31
2015	7	7	20	3	6	0.725	-0.115	3.973	0.013	0.01	0	43.4	38.7	60.6	135	121	0	34	31
2015	7	7	20	13	6	0.791	-0.098	3.973	0.013	0.01	0	43	38.7	70.5	134	121	0	34	31
2015	7	7	20	23	6	0.81	-0.115	3.976	0.013	0.01	0	43.4	39.1	74.4	135	122	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	7	20	33	6	0.797	-0.082	3.976	0.013	0.01	0	43	38.3	73.5	134	121	0	34	32
2015	7	7	20	43	6	0.774	-0.082	3.976	0.01	0.007	0	43.4	38.7	72.2	135	121	0	34	31
2015	7	7	20	53	6	0.758	-0.033	3.976	0.01	0.007	0	43.9	39.6	66.2	136	123	0	34	31
2015	7	7	21	3	6	0.791	-0.062	3.976	0.01	0.007	0	44.3	39.6	70.1	137	123	0	34	31
2015	7	7	21	13	6	0.748	-0.03	3.976	0.01	0.007	0	44.7	40.4	72.2	138	124	0	34	30
2015	7	7	21	23	6	0.771	-0.062	3.976	0.01	0.007	0	44.7	40	74	137	124	0	33	31
2015	7	7	21	33	6	0.797	-0.072	3.976	0.013	0.01	0	44.3	39.6	73.5	137	123	0	34	31
2015	7	7	21	43	6	0.81	-0.108	3.98	0.016	0.013	0	44.3	40	73.5	137	124	0	34	31
2015	7	7	21	53	6	0.745	-0.089	3.98	0.01	0.007	0	44.3	39.1	72.7	137	123	0	34	32
2015	7	7	22	3	6	0.827	-0.092	3.98	0.01	0.007	0	43.9	39.1	73.1	136	122	0	34	31
2015	7	7	22	13	6	0.768	-0.098	3.98	0.013	0.01	0	43.4	38.7	72.7	135	121	0	34	31
2015	7	7	22	23	6	0.823	-0.069	3.98	0.013	0.01	0	43.4	38.7	72.7	135	122	0	34	32
2015	7	7	22	33	6	0.781	-0.089	3.983	0.01	0.007	0	43.9	39.6	72.2	136	123	0	34	31
2015	7	7	22	43	6	0.794	-0.082	3.986	0.01	0.007	0	43.9	38.3	71.8	136	121	0	34	32
2015	7	7	22	53	6	0.791	-0.072	3.99	0.013	0.01	0	43.9	39.6	71.4	136	123	0	34	31
2015	7	7	23	3	6	0.709	-0.069	3.993	0.013	0.01	0	44.3	40	71	137	124	0	34	31
2015	7	7	23	13	6	0.768	-0.069	3.99	0.01	0.007	0	44.3	39.1	70.1	137	123	0	34	32
2015	7	7	23	23	6	0.761	-0.108	3.993	0.01	0.007	0	44.3	39.6	67.5	136	123	0	33	31
2015	7	7	23	33	6	0.807	-0.112	3.986	0.01	0.007	0	44.7	40	57.2	138	124	0	34	31
2015	7	7	23	43	6	0.787	-0.105	3.993	0.01	0.007	0	44.3	39.1	69.2	136	122	0	33	31
2015	7	7	23	53	6	0.771	-0.082	3.993	0.01	0.007	0	46	41.3	69.2	141	127	0	34	31
2015	7	8	0	3	6	0.804	-0.079	3.996	0.01	0.007	0	43.9	39.6	71.8	137	123	0	35	31
2015	7	8	0	13	6	0.791	-0.066	3.996	0.01	0.007	0	43.9	39.6	71.8	136	123	0	34	31
2015	7	8	0	23	6	0.778	-0.092	3.996	0.01	0.007	0	44.3	39.6	73.5	137	123	0	34	31
2015	7	8	0	33	6	0.778	-0.069	3.999	0.01	0.007	0	44.3	39.1	73.5	137	123	0	34	32
2015	7	8	0	43	6	0.768	-0.102	3.999	0.013	0.01	0	44.3	39.1	73.5	137	123	0	34	32
2015	7	8	0	53	6	0.791	-0.085	3.999	0.01	0.007	0	44.3	39.6	74.8	137	123	0	34	31
2015	7	8	1	3	6	0.791	-0.075	3.999	0.01	0.007	0	44.3	39.6	74	137	123	0	34	31
2015	7	8	1	13	6	0.801	-0.075	3.999	0.013	0.01	0	43.9	39.1	74.8	136	122	0	34	31
2015	7	8	1	23	6	0.807	-0.089	3.999	0.01	0.007	0	43.9	39.1	75.7	136	122	0	34	31
2015	7	8	1	33	6	0.81	-0.108	3.999	0.01	0.007	0	43.9	38.7	73.5	136	122	0	34	32
2015	7	8	1	43	6	0.758	-0.082	3.999	0.01	0.007	0	43.4	38.7	74.8	135	121	0	34	31
2015	7	8	1	53	6	0.774	-0.082	4.003	0.013	0.01	0	43	38.3	75.7	134	121	0	34	32
2015	7	8	2	3	6	0.807	-0.079	3.999	0.01	0.007	0	43.4	38.7	74	135	121	0	34	31
2015	7	8	2	13	6	0.794	-0.085	4.003	0.01	0.007	0	43.4	38.7	74.4	135	121	0	34	31
2015	7	8	2	23	6	0.794	-0.079	4.003	0.01	0.007	0	43.9	38.7	73.5	136	122	0	34	32
2015	7	8	2	33	6	0.807	-0.062	4.003	0.01	0.007	0	43.9	38.7	76.5	136	122	0	34	32
2015	7	8	2	43	6	0.774	-0.066	4.003	0.01	0.007	0	43.4	39.1	76.1	136	122	0	35	31
2015	7	8	2	53	6	0.801	-0.085	4.003	0.016	0.013	0	43.9	39.1	75.7	136	122	0	34	31
2015	7	8	3	3	6	0.778	-0.085	4.003	0.01	0.007	0	44.3	39.1	75.3	136	122	0	33	31
2015	7	8	3	13	6	0.778	-0.066	4.003	0.01	0.007	0	43.4	38.7	75.7	135	121	0	34	31
2015	7	8	3	23	6	0.781	-0.046	4.003	0.01	0.007	0	43.9	38.7	75.7	136	122	0	34	32
2015	7	8	3	33	6	0.843	-0.102	4.003	0.01	0.007	0	43.9	39.1	75.7	136	122	0	34	31
2015	7	8	3	43	6	0.735	-0.052	4.003	0.01	0.007	0	43.4	38.7	75.3	135	121	0	34	31
2015	7	8	3	53	6	0.758	-0.105	4.003	0.013	0.01	0	43.9	39.1	75.7	136	122	0	34	31
2015	7	8	4	3	6	0.833	-0.102	4.003	0.01	0.007	0	43.4	39.1	71	135	122	0	34	31
2015	7	8	4	13	6	0.801	-0.092	4.003	0.01	0.007	0	43.4	38.7	76.5	135	121	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	8	4	23	6	0.804	-0.095	4.003	0.013	0.01	0	43.4	38.7	76.1	135	122	0	34	32
2015	7	8	4	33	6	0.801	-0.059	4.003	0.01	0.007	0	43.9	38.7	72.2	136	122	0	34	32
2015	7	8	4	43	6	0.797	-0.082	4.003	0.01	0.007	0	43.4	38.7	74.4	135	122	0	34	32
2015	7	8	4	53	6	0.761	-0.059	4.003	0.01	0.007	0	43.9	38.7	75.3	136	122	0	34	32
2015	7	8	5	3	6	0.764	-0.062	4.003	0.013	0.01	0	43.9	39.1	75.3	136	122	0	34	31
2015	7	8	5	13	6	0.764	-0.095	4.003	0.01	0.007	0	43.9	39.6	74.8	136	123	0	34	31
2015	7	8	5	23	6	0.787	-0.062	4.003	0.01	0.007	0	43.9	39.1	75.7	135	122	0	33	31
2015	7	8	5	33	6	0.804	-0.082	4.006	0.013	0.01	0	43.4	38.7	76.1	135	122	0	34	32
2015	7	8	5	43	6	0.801	-0.108	4.003	0.01	0.007	0	43.9	38.7	75.3	136	122	0	34	32
2015	7	8	5	53	6	0.768	-0.069	4.003	0.016	0.013	0	43.9	39.1	76.1	136	122	0	34	31
2015	7	8	6	3	6	0.787	-0.059	4.006	0.01	0.007	0	43.4	39.1	75.7	136	122	0	35	31
2015	7	8	6	13	6	0.804	-0.046	4.006	0.01	0.007	0	43.9	39.1	76.1	136	122	0	34	31
2015	7	8	6	23	6	0.755	-0.069	4.006	0.01	0.007	0	43.9	39.1	75.3	136	122	0	34	31
2015	7	8	6	33	6	0.801	-0.066	4.006	0.01	0.007	0	43.9	38.7	74.8	136	122	0	34	32
2015	7	8	6	43	6	0.83	-0.105	4.006	0.01	0.007	0	43.4	38.3	76.1	135	121	0	34	32
2015	7	8	6	53	6	0.784	-0.089	4.006	0.016	0.013	0	43.4	38.7	75.3	136	122	0	35	32
2015	7	8	7	3	6	0.784	-0.131	4.006	0.013	0.01	0	43.9	39.1	75.3	136	122	0	34	31
2015	7	8	7	13	6	0.774	-0.112	4.006	0.01	0.007	0	43.9	39.1	74.8	136	122	0	34	31
2015	7	8	7	23	6	0.797	-0.082	4.006	0.01	0.007	0	43.9	39.1	74.4	136	122	0	34	31
2015	7	8	7	33	6	0.771	-0.066	4.006	0.013	0.01	0	43.9	39.1	74.4	136	123	0	34	32
2015	7	8	7	43	6	0.807	-0.095	4.009	0.013	0.01	0	43.9	39.1	74.4	136	122	0	34	31
2015	7	8	7	53	6	0.801	-0.082	4.006	0.01	0.007	0	43.9	38.7	74.4	136	122	0	34	32
2015	7	8	8	3	6	0.774	-0.112	4.009	0.016	0.013	0	43.9	38.7	74.4	136	122	0	34	32
2015	7	8	8	13	6	0.801	-0.092	4.009	0.013	0.01	0	43.4	38.7	74	135	122	0	34	32
2015	7	8	8	23	6	0.751	-0.082	4.009	0.016	0.013	0	43.4	38.7	74.8	135	122	0	34	32
2015	7	8	8	33	6	0.791	-0.089	4.009	0.01	0.007	0	43.9	38.7	74	135	122	0	33	32
2015	7	8	8	43	6	0.817	-0.102	4.009	0.01	0.007	0	43.4	38.7	74.4	135	121	0	34	31
2015	7	8	8	53	6	0.84	-0.089	4.009	0.01	0.007	0	43	38.3	74.4	134	121	0	34	32
2015	7	8	9	3	6	0.814	-0.098	4.009	0.01	0.007	0	43	38.3	74	134	121	0	34	32
2015	7	8	9	13	6	0.797	-0.095	4.009	0.01	0.007	0	43.9	38.7	74	135	122	0	33	32
2015	7	8	9	23	6	0.787	-0.049	4.009	0.016	0.013	0	43	39.1	73.5	135	122	0	35	31
2015	7	8	9	33	6	0.755	-0.059	4.009	0.013	0.01	0	43.4	38.7	74.4	135	121	0	34	31
2015	7	8	9	43	6	0.784	-0.098	4.012	0.01	0.007	0	43	37.8	73.5	134	120	0	34	32
2015	7	8	9	53	6	0.787	-0.092	4.012	0.01	0.007	0	43	38.7	74.8	134	121	0	34	31
2015	7	8	10	3	6	0.758	-0.105	4.012	0.01	0.007	0	43	38.7	73.1	134	121	0	34	31
2015	7	8	10	13	6	0.804	-0.092	4.012	0.01	0.007	0	42.6	37.8	74.4	133	120	0	34	32
2015	7	8	10	23	6	0.751	-0.112	4.012	0.01	0.007	0	42.6	38.7	72.7	134	121	0	35	31
2015	7	8	10	33	6	0.784	-0.105	4.012	0.013	0.01	0	42.6	38.3	73.1	133	120	0	34	31
2015	7	8	10	43	6	0.725	-0.089	4.012	0.013	0.01	0	42.1	37.8	74	133	120	0	35	32
2015	7	8	10	53	6	0.771	-0.115	4.012	0.013	0.01	0	43	38.7	73.5	135	122	0	35	32
2015	7	8	11	3	6	0.781	-0.098	4.012	0.01	0.007	0	43.9	39.1	70.5	136	122	0	34	31
2015	7	8	11	13	6	0.771	-0.062	4.012	0.01	0.007	0	43.4	39.1	72.2	135	122	0	34	31
2015	7	8	11	23	6	0.804	-0.092	4.012	0.013	0.01	0	43.4	39.1	64.9	135	122	0	34	31
2015	7	8	11	33	6	0.778	-0.075	4.012	0.013	0.01	0	43.4	39.6	58.9	136	123	0	35	31
2015	7	8	11	43	6	0.83	-0.079	4.012	0.013	0.01	0	43.9	39.1	58	136	122	0	34	31
2015	7	8	11	53	6	0.768	-0.069	4.012	0.013	0.01	0	43.4	38.7	57.6	135	122	0	34	32
2015	7	8	12	3	6	0.794	-0.118	4.012	0.01	0.007	0	43.9	38.7	56.8	136	122	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	8	12	13	6	0.768	-0.092	4.016	0.01	0.007	0	43.4	38.7	55.9	135	122	0	34	32
2015	7	8	12	23	6	0.751	-0.092	4.016	0.01	0.007	0	43.9	39.1	54.6	136	123	0	34	32
2015	7	8	12	33	6	0.781	-0.066	4.016	0.01	0.007	0	43.4	39.1	52	135	122	0	34	31
2015	7	8	12	43	6	0.758	-0.075	4.016	0.01	0.007	0	43.4	39.1	52.9	135	122	0	34	31
2015	7	8	12	53	6	0.751	-0.059	4.012	0.01	0.007	0	43.9	38.7	55	136	122	0	34	32
2015	7	8	13	3	6	0.758	-0.082	4.016	0.013	0.01	0	43.4	39.1	51.2	136	123	0	35	32
2015	7	8	13	13	6	0.745	-0.092	4.012	0.013	0.01	0	43.4	38.7	55	135	122	0	34	32
2015	7	8	13	23	6	0.761	-0.062	4.016	0.013	0.01	0	43.4	39.1	56.3	135	122	0	34	31
2015	7	8	13	33	6	0.764	-0.112	4.012	0.01	0.007	0	43.4	39.1	56.3	135	122	0	34	31
2015	7	8	13	43	6	0.755	-0.072	4.019	0.013	0.01	0	43.4	38.7	52.9	135	122	0	34	32
2015	7	8	13	53	6	0.771	-0.082	4.012	0.01	0.007	0	43.4	39.1	57.2	135	122	0	34	31
2015	7	8	14	3	6	0.719	-0.082	4.016	0.01	0.007	0	43.4	39.6	54.6	136	123	0	35	31
2015	7	8	14	13	6	0.738	-0.072	4.012	0.01	0.007	0	43.9	38.7	56.3	136	122	0	34	32
2015	7	8	14	23	6	0.761	-0.098	4.012	0.01	0.007	0	43	39.1	55	135	122	0	35	31
2015	7	8	14	33	6	0.774	-0.072	4.012	0.01	0.007	0	43.9	38.7	52	136	122	0	34	32
2015	7	8	14	43	6	0.771	-0.082	4.012	0.013	0.01	0	43.9	39.6	54.6	136	123	0	34	31
2015	7	8	14	53	6	0.781	-0.082	4.016	0.01	0.007	0	44.3	39.1	50.7	137	123	0	34	32
2015	7	8	15	3	6	0.751	-0.069	4.012	0.013	0.01	0	43.9	38.7	54.6	136	122	0	34	32
2015	7	8	15	13	6	0.771	-0.062	4.009	0.016	0.013	0	43.4	38.7	60.2	136	122	0	35	32
2015	7	8	15	23	6	0.774	-0.105	4.009	0.013	0.01	0	43.9	38.7	55.5	135	121	0	33	31
2015	7	8	15	33	6	0.738	-0.102	4.012	0.01	0.007	0	43	37.8	54.2	134	120	0	34	32
2015	7	8	15	43	6	0.725	-0.069	4.012	0.01	0.007	0	43.4	38.7	56.3	135	121	0	34	31
2015	7	8	15	53	6	0.751	-0.069	4.012	0.013	0.01	0	43	38.3	57.2	134	120	0	34	31
2015	7	8	16	3	6	0.758	-0.066	4.009	0.013	0.01	0	43	37.8	57.2	134	120	0	34	32
2015	7	8	16	13	6	0.774	-0.115	4.012	0.013	0.01	0	43.4	38.7	56.3	135	121	0	34	31
2015	7	8	16	23	6	0.781	-0.112	4.012	0.01	0.007	0	43.9	39.1	54.2	136	122	0	34	31
2015	7	8	16	33	6	0.774	-0.082	4.009	0.016	0.013	0	43.9	38.3	59.3	135	121	0	33	32
2015	7	8	16	43	6	0.709	-0.102	4.009	0.01	0.007	0	44.3	39.6	58	137	123	0	34	31
2015	7	8	16	53	6	0.738	-0.046	4.012	0.01	0.007	0	43.9	38.7	55.9	136	122	0	34	32
2015	7	8	17	3	6	0.741	-0.085	4.012	0.01	0.007	0	44.3	40	54.2	137	124	0	34	31
2015	7	8	17	13	6	0.781	-0.095	4.012	0.013	0.01	0	44.3	39.1	57.2	137	123	0	34	32
2015	7	8	17	23	6	0.778	-0.066	4.012	0.01	0.007	0	44.3	39.6	51.6	137	123	0	34	31
2015	7	8	17	33	6	0.764	-0.082	4.012	0.01	0.007	0	44.3	39.6	52	137	123	0	34	31
2015	7	8	17	43	6	0.771	-0.095	4.012	0.01	0.007	0	44.3	39.6	55	137	123	0	34	31
2015	7	8	17	53	6	0.768	-0.098	4.012	0.013	0.01	0	44.7	39.6	54.6	137	123	0	33	31
2015	7	8	18	3	6	0.781	-0.105	4.012	0.01	0.007	0	43.9	38.7	55.9	136	122	0	34	32
2015	7	8	18	13	6	0.755	-0.112	4.009	0.01	0.007	0	43.4	38.3	55.5	135	121	0	34	32
2015	7	8	18	23	6	0.774	-0.082	4.012	0.01	0.007	0	43.4	38.3	56.3	135	121	0	34	32
2015	7	8	18	33	6	0.761	-0.082	4.012	0.013	0.01	0	43.4	38.3	53.3	135	121	0	34	32
2015	7	8	18	43	6	0.761	-0.092	4.012	0.01	0.007	0	43.9	39.1	55.9	136	122	0	34	31
2015	7	8	18	53	6	0.709	-0.102	4.009	0.01	0.007	0	43.9	38.7	58.5	136	121	0	34	31
2015	7	8	19	3	6	0.761	-0.125	4.009	0.01	0.007	0	43.4	38.3	60.6	135	120	0	34	31
2015	7	8	19	13	6	0.771	-0.089	4.009	0.013	0.01	0	43	37.4	64.1	134	119	0	34	32
2015	7	8	19	23	6	0.797	-0.082	4.012	0.013	0.01	0	42.6	37.8	72.7	134	119	0	35	31
2015	7	8	19	33	6	0.787	-0.072	4.012	0.01	0.007	0	43.4	38.3	72.2	135	120	0	34	31
2015	7	8	19	43	6	0.823	-0.069	4.012	0.01	0.007	0	43.4	37.8	74.4	135	120	0	34	32
2015	7	8	19	53	6	0.801	-0.085	4.012	0.013	0.01	0	43	37.8	65.8	134	120	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	8	20	3	6	0.791	-0.079	4.012	0.01	0.007	0	43.4	38.7	59.3	135	121	0	34	31
2015	7	8	20	13	6	0.814	-0.098	4.012	0.013	0.01	0	43.9	39.1	60.6	136	122	0	34	31
2015	7	8	20	23	6	0.774	-0.066	4.012	0.01	0.007	0	43	39.1	66.7	135	122	0	35	31
2015	7	8	20	33	6	0.823	-0.075	4.012	0.01	0.007	0	43.9	39.1	65.8	136	122	0	34	31
2015	7	8	20	43	6	0.787	-0.098	4.016	0.013	0.01	0	43.9	39.1	55.9	136	122	0	34	31
2015	7	8	20	53	6	0.801	-0.079	4.016	0.013	0.01	0	44.3	39.1	54.6	137	123	0	34	32
2015	7	8	21	3	6	0.83	-0.089	4.016	0.013	0.01	0	44.3	39.1	67.9	137	123	0	34	32
2015	7	8	21	13	6	0.791	-0.089	4.016	0.013	0.01	0	44.3	39.6	71	137	123	0	34	31
2015	7	8	21	23	6	0.814	-0.03	4.016	0.016	0.013	0	43.4	38.7	72.7	135	121	0	34	31
2015	7	8	21	33	6	0.787	-0.039	4.019	0.01	0.007	0	43	38.3	73.1	134	120	0	34	31
2015	7	8	21	43	6	0.794	-0.069	4.019	0.013	0.01	0	42.6	37.8	71.8	133	120	0	34	32
2015	7	8	21	53	6	0.771	-0.095	4.022	0.01	0.007	0	43.4	37.4	72.7	134	119	0	33	32
2015	7	8	22	3	6	0.764	-0.072	4.022	0.016	0.013	0	42.6	37.8	71.8	133	119	0	34	31
2015	7	8	22	13	6	0.764	-0.098	4.022	0.01	0.007	0	43	37.8	72.2	134	119	0	34	31
2015	7	8	22	23	6	0.761	-0.098	4.026	0.01	0.007	0	43	37.8	72.2	134	119	0	34	31
2015	7	8	22	33	6	0.781	-0.062	4.029	0.01	0.007	0	43	38.3	72.7	134	120	0	34	31
2015	7	8	22	43	6	0.784	-0.098	4.029	0.01	0.007	0	43	38.3	72.2	134	120	0	34	31
2015	7	8	22	53	6	0.823	-0.062	4.029	0.01	0.007	0	43.4	38.3	69.7	134	121	0	33	32
2015	7	8	23	3	6	0.784	-0.075	4.029	0.01	0.007	0	43.4	38.7	71.4	135	121	0	34	31
2015	7	8	23	13	6	0.781	-0.062	4.029	0.01	0.007	0	43.9	38.7	69.2	136	121	0	34	31
2015	7	8	23	23	6	0.781	-0.089	4.029	0.013	0.01	0	43	37.8	64.9	134	120	0	34	32
2015	7	8	23	33	6	0.827	-0.069	4.029	0.01	0.007	0	43	37.8	62.4	134	120	0	34	32
2015	7	8	23	43	6	0.768	-0.102	4.032	0.01	0.007	0	44.3	38.3	61.5	136	121	0	33	32
2015	7	8	23	53	6	0.823	-0.095	4.032	0.01	0.007	0	43.4	38.3	73.5	135	121	0	34	32
2015	7	9	0	3	6	0.768	-0.069	4.032	0.01	0.007	0	43.4	38.7	69.2	135	121	0	34	31
2015	7	9	0	13	6	0.784	-0.049	4.032	0.01	0.007	0	43.4	38.7	71	135	121	0	34	31
2015	7	9	0	23	6	0.797	-0.105	4.032	0.01	0.007	0	43	37.8	69.7	134	120	0	34	32
2015	7	9	0	33	6	0.764	-0.089	4.035	0.01	0.007	0	43.4	38.7	63.2	135	121	0	34	31
2015	7	9	0	43	6	0.764	-0.082	4.032	0.01	0.007	0	43.9	39.1	55.9	136	122	0	34	31
2015	7	9	0	53	6	0.787	-0.082	4.035	0.013	0.01	0	44.3	39.6	56.8	137	123	0	34	31
2015	7	9	1	3	6	0.771	-0.082	4.035	0.013	0.01	0	44.3	39.1	61.1	137	123	0	34	32
2015	7	9	1	13	6	0.801	-0.092	4.035	0.01	0.007	0	44.3	39.6	61.1	137	123	0	34	31
2015	7	9	1	23	6	0.807	-0.062	4.035	0.013	0.01	0	43.4	38.7	65.4	136	122	0	35	32
2015	7	9	1	33	6	0.791	-0.079	4.039	0.01	0.007	0	43.9	38.3	74.8	136	121	0	34	32
2015	7	9	1	43	6	0.81	-0.085	4.039	0.013	0.01	0	43.4	38.3	75.7	135	121	0	34	32
2015	7	9	1	53	6	0.764	-0.105	4.039	0.01	0.007	0	43	38.7	75.3	135	121	0	35	31
2015	7	9	2	3	6	0.804	-0.108	4.039	0.016	0.013	0	43	37.8	75.7	134	120	0	34	32
2015	7	9	2	13	6	0.768	-0.059	4.039	0.013	0.01	0	43	37.8	75.7	134	120	0	34	32
2015	7	9	2	23	6	0.784	-0.069	4.039	0.01	0.007	0	42.6	38.3	74.8	134	120	0	35	31
2015	7	9	2	33	6	0.833	-0.092	4.039	0.013	0.01	0	42.6	37.4	75.3	133	119	0	34	32
2015	7	9	2	43	6	0.827	-0.102	4.039	0.01	0.007	0	42.6	37.8	75.7	133	119	0	34	31
2015	7	9	2	53	6	0.801	-0.082	4.039	0.01	0.007	0	42.6	37.8	76.1	133	119	0	34	31
2015	7	9	3	3	6	0.787	-0.085	4.039	0.01	0.007	0	43	37.8	75.7	134	120	0	34	32
2015	7	9	3	13	6	0.725	-0.052	4.039	0.01	0.007	0	43	37.8	76.1	134	120	0	34	32
2015	7	9	3	23	6	0.807	-0.056	4.039	0.013	0.01	0	42.6	37.4	74.8	133	119	0	34	32
2015	7	9	3	33	6	0.804	-0.095	4.039	0.01	0.007	0	42.1	37.8	75.7	133	119	0	35	31
2015	7	9	3	43	6	0.791	-0.089	4.039	0.01	0.007	0	42.6	37.4	74	133	119	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	9	3	53	6	0.804	-0.108	4.039	0.01	0.007	0	42.6	37.4	74.4	133	119	0	34	32
2015	7	9	4	3	6	0.804	-0.079	4.039	0.016	0.013	0	42.6	37.8	73.5	133	119	0	34	31
2015	7	9	4	13	6	0.81	-0.102	4.039	0.013	0.01	0	42.1	37.8	74.8	133	119	0	35	31
2015	7	9	4	23	6	0.781	-0.082	4.039	0.01	0.007	0	42.6	37.4	74.8	133	119	0	34	32
2015	7	9	4	33	6	0.804	-0.085	4.039	0.01	0.007	0	42.6	37.4	73.5	133	119	0	34	32
2015	7	9	4	43	6	0.83	-0.066	4.042	0.01	0.007	0	42.1	37	75.3	132	118	0	34	32
2015	7	9	4	53	6	0.732	-0.079	4.042	0.01	0.007	0	42.1	37.4	75.3	132	118	0	34	31
2015	7	9	5	3	6	0.794	-0.075	4.042	0.01	0.007	0	42.1	37	76.1	132	118	0	34	32
2015	7	9	5	13	6	0.781	-0.046	4.042	0.016	0.013	0	42.6	37.8	75.7	133	119	0	34	31
2015	7	9	5	23	6	0.781	-0.075	4.042	0.01	0.007	0	42.6	37.8	74.4	133	119	0	34	31
2015	7	9	5	33	6	0.764	-0.062	4.042	0.01	0.007	0	42.1	37	74.4	132	118	0	34	32
2015	7	9	5	43	6	0.781	-0.089	4.042	0.01	0.007	0	42.1	37	74	132	118	0	34	32
2015	7	9	5	53	6	0.801	-0.098	4.042	0.01	0.007	0	42.1	37.4	75.3	132	118	0	34	31
2015	7	9	6	3	6	0.758	-0.098	4.042	0.01	0.007	0	42.1	36.5	75.3	132	117	0	34	32
2015	7	9	6	13	6	0.807	-0.098	4.042	0.01	0.007	0	41.7	36.5	74.8	131	117	0	34	32
2015	7	9	6	23	6	0.83	-0.095	4.045	0.013	0.01	0	41.7	36.1	74.8	131	116	0	34	32
2015	7	9	6	33	6	0.797	-0.095	4.042	0.01	0.007	0	41.3	36.5	75.3	130	116	0	34	31
2015	7	9	6	43	6	0.794	-0.095	4.045	0.013	0.01	0	40.9	36.5	75.3	130	116	0	35	31
2015	7	9	6	53	6	0.823	-0.095	4.045	0.013	0.01	0	41.3	37	74.8	130	117	0	34	31
2015	7	9	7	3	6	0.758	-0.072	4.045	0.01	0.007	0	41.3	36.5	74.4	131	117	0	35	32
2015	7	9	7	13	6	0.781	-0.079	4.045	0.01	0.007	0	41.3	36.1	73.5	130	116	0	34	32
2015	7	9	7	23	6	0.797	-0.108	4.045	0.01	0.007	0	40.4	36.5	72.7	129	116	0	35	31
2015	7	9	7	33	6	0.755	-0.085	4.045	0.016	0.013	0	40.4	35.7	73.5	129	115	0	35	32
2015	7	9	7	43	6	0.801	-0.056	4.049	0.01	0.007	0	40.9	35.7	73.5	129	115	0	34	32
2015	7	9	7	53	6	0.781	-0.079	4.049	0.01	0.007	0	40.9	35.7	73.5	129	115	0	34	32
2015	7	9	8	3	6	0.807	-0.082	4.049	0.013	0.01	0	40.4	35.7	73.5	128	115	0	34	32
2015	7	9	8	13	6	0.781	-0.118	4.049	0.01	0.007	0	40.9	36.1	72.2	129	115	0	34	31
2015	7	9	8	23	6	0.794	-0.095	4.052	0.01	0.007	0	40.4	35.7	72.7	128	114	0	34	31
2015	7	9	8	33	6	0.807	-0.089	4.052	0.01	0.007	0	40.4	35.3	73.5	128	114	0	34	32
2015	7	9	8	43	6	0.807	-0.095	4.055	0.01	0.007	0	40.4	36.1	73.1	128	115	0	34	31
2015	7	9	8	53	6	0.755	-0.069	4.055	0.01	0.007	0	40.9	36.1	72.2	130	116	0	35	32
2015	7	9	9	3	6	0.732	-0.089	4.055	0.016	0.016	0	40.9	36.1	69.2	129	115	0	34	31
2015	7	9	9	13	6	0.774	-0.115	4.055	0.01	0.007	0	40.9	35.7	68.8	129	115	0	34	32
2015	7	9	9	23	6	0.807	-0.105	4.058	0.013	0.01	0	40.4	35.7	70.5	129	115	0	35	32
2015	7	9	9	33	6	0.778	-0.108	4.055	0.01	0.007	0	40.4	36.1	61.1	128	115	0	34	31
2015	7	9	9	43	6	0.781	-0.128	4.058	0.013	0.01	0	40.4	35.7	71.8	128	115	0	34	32
2015	7	9	9	53	6	0.801	-0.112	4.058	0.01	0.007	0	40.4	35.7	66.2	129	115	0	35	32
2015	7	9	10	3	6	0.804	-0.079	4.062	0.01	0.007	0	40.4	36.1	71.8	128	115	0	34	31
2015	7	9	10	13	6	0.774	-0.089	4.062	0.013	0.01	0	40.9	35.7	73.5	129	115	0	34	32
2015	7	9	10	23	6	0.797	-0.102	4.062	0.013	0.01	0	40.9	36.1	72.7	129	115	0	34	31
2015	7	9	10	33	6	0.781	-0.089	4.062	0.01	0.007	0	40.4	35.3	73.5	128	114	0	34	32
2015	7	9	10	43	6	0.784	-0.095	4.062	0.01	0.007	0	40.9	36.1	74	129	115	0	34	31
2015	7	9	10	53	6	0.791	-0.095	4.062	0.01	0.007	0	40.4	36.1	74.4	128	115	0	34	31
2015	7	9	11	3	6	0.778	-0.089	4.062	0.013	0.01	0	40.4	35.3	67.9	128	114	0	34	32
2015	7	9	11	13	6	0.771	-0.075	4.058	0.01	0.007	0	40.4	35.7	56.8	129	115	0	35	32
2015	7	9	11	23	6	0.778	-0.089	4.058	0.013	0.01	0	41.3	36.5	57.6	130	116	0	34	31
2015	7	9	11	33	6	0.781	-0.079	4.062	0.01	0.007	0	41.3	36.5	57.6	131	117	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	9	11	43	6	0.784	-0.089	4.062	0.01	0.007	0	41.3	36.1	61.9	130	116	0	34	32
2015	7	9	11	53	6	0.771	-0.092	4.062	0.013	0.01	0	41.7	36.1	59.3	131	116	0	34	32
2015	7	9	12	3	6	0.764	-0.092	4.062	0.01	0.007	0	41.3	36.5	59.3	130	117	0	34	32
2015	7	9	12	13	6	0.814	-0.072	4.065	0.01	0.007	0	42.1	37	58.9	132	118	0	34	32
2015	7	9	12	23	6	0.781	-0.079	4.065	0.01	0.007	0	43	37.8	65.4	134	120	0	34	32
2015	7	9	12	33	6	0.807	-0.072	4.065	0.013	0.01	0	43.9	38.3	65.4	136	121	0	34	32
2015	7	9	12	43	6	0.817	-0.089	4.068	0.01	0.007	0	43.9	39.1	65.8	136	122	0	34	31
2015	7	9	12	53	6	0.81	-0.092	4.068	0.01	0.007	0	44.3	39.6	70.5	138	124	0	35	32
2015	7	9	13	3	6	0.784	-0.098	4.068	0.01	0.007	0	44.7	39.6	63.6	138	124	0	34	32
2015	7	9	13	13	6	0.804	-0.092	4.068	0.01	0.007	0	45.6	40.4	52.9	140	126	0	34	32
2015	7	9	13	23	6	0.748	-0.095	4.068	0.013	0.01	0	45.6	40.9	69.2	141	127	0	35	32
2015	7	9	13	33	6	0.86	-0.082	4.072	0.01	0.007	0	46	40.4	74.4	141	126	0	34	32
2015	7	9	13	43	6	0.801	-0.079	4.072	0.01	0.007	0	45.6	40.4	76.1	140	125	0	34	31
2015	7	9	13	53	6	0.814	-0.085	4.072	0.01	0.007	0	45.2	40	76.5	139	125	0	34	32
2015	7	9	14	3	6	0.794	-0.112	4.072	0.013	0.01	0	45.2	40	77	139	125	0	34	32
2015	7	9	14	13	6	0.794	-0.075	4.072	0.01	0.007	0	45.2	40	74	139	125	0	34	32
2015	7	9	14	23	6	0.774	-0.089	4.072	0.01	0.007	0	45.2	40	67.1	139	125	0	34	32
2015	7	9	14	33	6	0.787	-0.059	4.075	0.01	0.007	0	45.2	40.4	73.5	139	126	0	34	32
2015	7	9	14	43	6	0.794	-0.069	4.075	0.013	0.01	0	44.7	40	71.8	138	125	0	34	32
2015	7	9	14	53	6	0.768	-0.052	4.072	0.01	0.007	0	44.3	40	65.4	138	124	0	35	31
2015	7	9	15	3	6	0.801	-0.082	4.075	0.01	0.007	0	44.7	40	74.8	138	124	0	34	31
2015	7	9	15	13	6	0.791	-0.105	4.072	0.01	0.007	0	44.3	38.7	76.1	137	122	0	34	32
2015	7	9	15	23	6	0.814	-0.095	4.075	0.01	0.007	0	43.4	38.7	76.5	135	121	0	34	31
2015	7	9	15	33	6	0.797	-0.092	4.075	0.01	0.007	0	43	37.8	75.3	134	120	0	34	32
2015	7	9	15	43	6	0.804	-0.075	4.075	0.013	0.01	0	42.6	37.8	77	133	119	0	34	31
2015	7	9	15	53	6	0.814	-0.079	4.075	0.01	0.007	0	43	37.8	74.8	134	120	0	34	32
2015	7	9	16	3	6	0.81	-0.075	4.075	0.01	0.007	0	42.6	37.4	74.8	133	119	0	34	32
2015	7	9	16	13	6	0.787	-0.095	4.075	0.01	0.007	0	43	37.4	76.1	134	120	0	34	33
2015	7	9	16	23	6	0.814	-0.102	4.075	0.013	0.01	0	43	37.8	74.8	134	120	0	34	32
2015	7	9	16	33	6	0.758	-0.079	4.075	0.013	0.01	0	42.1	37.4	76.1	133	119	0	35	32
2015	7	9	16	43	6	0.787	-0.102	4.075	0.01	0.007	0	42.6	37.4	75.3	133	119	0	34	32
2015	7	9	16	53	6	0.82	-0.085	4.075	0.01	0.007	0	42.1	37	76.5	132	118	0	34	32
2015	7	9	17	3	6	0.82	-0.069	4.075	0.013	0.01	0	42.6	37	75.7	133	118	0	34	32
2015	7	9	17	13	6	0.781	-0.046	4.075	0.013	0.01	0	42.1	37	74.4	132	118	0	34	32
2015	7	9	17	23	6	0.804	-0.095	4.078	0.01	0.007	0	41.7	37	75.7	131	117	0	34	31
2015	7	9	17	33	6	0.778	-0.079	4.078	0.013	0.01	0	42.1	37.4	76.1	132	118	0	34	31
2015	7	9	17	43	6	0.81	-0.085	4.078	0.013	0.01	0	42.1	36.5	76.1	132	117	0	34	32
2015	7	9	17	53	6	0.801	-0.062	4.078	0.01	0.007	0	42.1	36.5	76.5	132	117	0	34	32
2015	7	9	18	3	6	0.784	-0.079	4.078	0.01	0.007	0	41.7	36.5	74.8	131	117	0	34	32
2015	7	9	18	13	6	0.784	-0.072	4.078	0.013	0.01	0	42.6	37.4	75.7	133	119	0	34	32
2015	7	9	18	23	6	0.814	-0.056	4.078	0.01	0.007	0	43	37.4	74.4	134	119	0	34	32
2015	7	9	18	33	6	0.797	-0.089	4.078	0.01	0.007	0	42.6	37.4	75.7	133	118	0	34	31
2015	7	9	18	43	6	0.82	-0.102	4.081	0.01	0.007	0	42.1	37	75.3	132	118	0	34	32
2015	7	9	18	53	6	0.801	-0.112	4.081	0.013	0.01	0	42.6	37.4	75.3	133	119	0	34	32
2015	7	9	19	3	6	0.83	-0.112	4.081	0.013	0.01	0	41.7	37.4	75.3	132	118	0	35	31
2015	7	9	19	13	6	0.794	-0.108	4.081	0.01	0.007	0	42.1	37	75.7	132	118	0	34	32
2015	7	9	19	23	6	0.83	-0.102	4.081	0.013	0.01	0	42.1	37.4	74	133	119	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	9	19	33	6	0.827	-0.112	4.081	0.01	0.007	0	42.6	37	74.8	133	118	0	34	32
2015	7	9	19	43	6	0.814	-0.079	4.081	0.01	0.007	0	42.1	37.4	74	133	119	0	35	32
2015	7	9	19	53	6	0.827	-0.079	4.085	0.013	0.01	0	41.7	37.4	74	132	118	0	35	31
2015	7	9	20	3	6	0.817	-0.066	4.085	0.01	0.007	0	42.1	37.4	74	133	119	0	35	32
2015	7	9	20	13	6	0.817	-0.089	4.085	0.01	0.007	0	42.6	37.4	73.1	133	119	0	34	32
2015	7	9	20	23	6	0.84	-0.072	4.085	0.01	0.007	0	42.6	37	73.5	133	118	0	34	32
2015	7	9	20	33	6	0.804	-0.092	4.085	0.013	0.01	0	42.6	37.4	72.7	133	119	0	34	32
2015	7	9	20	43	6	0.827	-0.075	4.085	0.013	0.01	0	42.6	37.4	72.2	133	119	0	34	32
2015	7	9	20	53	6	0.837	-0.079	4.088	0.01	0.007	0	43	37.8	71	134	119	0	34	31
2015	7	9	21	3	6	0.817	-0.066	4.088	0.013	0.01	0	42.6	37.8	71	133	119	0	34	31
2015	7	9	21	13	6	0.794	-0.121	4.088	0.01	0.007	0	42.6	37.4	72.2	133	119	0	34	32
2015	7	9	21	23	6	0.827	-0.089	4.091	0.01	0.007	0	42.6	37.8	72.2	133	119	0	34	31
2015	7	9	21	33	6	0.807	-0.098	4.088	0.013	0.01	0	42.6	37.8	71	134	120	0	35	32
2015	7	9	21	43	6	0.81	-0.072	4.094	0.013	0.01	0	42.6	38.3	72.7	134	120	0	35	31
2015	7	9	21	53	6	0.791	-0.079	4.094	0.01	0.007	0	42.6	38.3	73.1	134	120	0	35	31
2015	7	9	22	3	6	0.81	-0.066	4.094	0.01	0.007	0	43.4	38.3	72.7	135	121	0	34	32
2015	7	9	22	13	6	0.784	-0.072	4.094	0.01	0.007	0	43	38.3	73.1	135	121	0	35	32
2015	7	9	22	23	6	0.843	-0.108	4.094	0.01	0.007	0	42.6	37.8	72.7	134	120	0	35	32
2015	7	9	22	33	6	0.797	-0.069	4.094	0.01	0.007	0	43	37.8	73.1	134	120	0	34	32
2015	7	9	22	43	6	0.801	-0.072	4.094	0.01	0.007	0	43	38.3	73.1	135	121	0	35	32
2015	7	9	22	53	6	0.837	-0.092	4.094	0.01	0.007	0	43	37.8	72.7	134	120	0	34	32
2015	7	9	23	3	6	0.761	-0.082	4.094	0.01	0.007	0	43	37	72.7	134	119	0	34	33
2015	7	9	23	13	6	0.856	-0.089	4.094	0.01	0.007	0	43	38.3	73.1	134	120	0	34	31
2015	7	9	23	23	6	0.781	-0.108	4.094	0.01	0.007	0	43	37.8	73.1	134	120	0	34	32
2015	7	9	23	33	6	0.814	-0.079	4.094	0.01	0.007	0	43	37.8	72.7	134	120	0	34	32
2015	7	9	23	43	6	0.814	-0.095	4.091	0.01	0.007	0	43	38.3	72.2	135	121	0	35	32
2015	7	9	23	53	6	0.83	-0.079	4.091	0.01	0.007	0	43	37.8	72.7	134	120	0	34	32
2015	7	10	0	3	6	0.823	-0.089	4.091	0.01	0.007	0	42.6	38.3	71.8	134	120	0	35	31
2015	7	10	0	13	6	0.823	-0.095	4.091	0.01	0.007	0	42.6	38.3	72.2	134	120	0	35	31
2015	7	10	0	23	6	0.807	-0.095	4.085	0.01	0.007	0	42.6	37.8	72.2	134	120	0	35	32
2015	7	10	0	33	6	0.827	-0.098	4.085	0.01	0.007	0	43	38.3	72.2	134	120	0	34	31
2015	7	10	0	43	6	0.794	-0.082	4.081	0.01	0.007	0	43.4	38.3	72.7	135	120	0	34	31
2015	7	10	0	53	6	0.791	-0.085	4.081	0.01	0.007	0	43	37.8	72.2	134	120	0	34	32
2015	7	10	1	3	6	0.751	-0.095	4.081	0.01	0.007	0	43	38.3	73.1	135	120	0	35	31
2015	7	10	1	13	6	0.807	-0.079	4.078	0.01	0.007	0	43.4	37.4	72.2	134	120	0	33	33
2015	7	10	1	23	6	0.837	-0.069	4.078	0.013	0.01	0	43	37.4	73.5	134	120	0	34	33
2015	7	10	1	33	6	0.774	-0.072	4.078	0.01	0.007	0	43.4	38.3	73.5	135	120	0	34	31
2015	7	10	1	43	6	0.797	-0.069	4.078	0.01	0.007	0	42.1	37.4	74	133	119	0	35	32
2015	7	10	1	53	6	0.833	-0.066	4.075	0.01	0.007	0	43	38.3	74	134	120	0	34	31
2015	7	10	2	3	6	0.784	-0.102	4.075	0.01	0.007	0	42.6	37.8	74	134	120	0	35	32
2015	7	10	2	13	6	0.784	-0.102	4.075	0.01	0.007	0	42.6	37.8	74.4	134	120	0	35	32
2015	7	10	2	23	6	0.85	-0.046	4.072	0.013	0.01	0	43	37.8	74	134	120	0	34	32
2015	7	10	2	33	6	0.807	-0.092	4.072	0.013	0.01	0	43.4	38.3	71	135	121	0	34	32
2015	7	10	2	43	6	0.817	-0.112	4.072	0.013	0.01	0	43	37.8	74.4	134	120	0	34	32
2015	7	10	2	53	6	0.843	-0.121	4.072	0.01	0.007	0	43	37.8	75.3	134	120	0	34	32
2015	7	10	3	3	6	0.814	-0.095	4.068	0.01	0.007	0	43	38.7	75.3	135	121	0	35	31
2015	7	10	3	13	6	0.784	-0.072	4.068	0.013	0.01	0	43	37.8	75.7	135	120	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	10	3	23	6	0.778	-0.062	4.068	0.01	0.007	0	43	38.3	75.7	134	121	0	34	32
2015	7	10	3	33	6	0.768	-0.085	4.065	0.013	0.01	0	42.6	37.8	74.8	134	120	0	35	32
2015	7	10	3	43	6	0.781	-0.079	4.065	0.01	0.007	0	43	37.8	75.3	134	120	0	34	32
2015	7	10	3	53	6	0.801	-0.075	4.065	0.01	0.007	0	42.6	37.4	75.3	134	119	0	35	32
2015	7	10	4	3	6	0.751	-0.085	4.065	0.01	0.007	0	42.6	37.8	75.7	134	120	0	35	32
2015	7	10	4	13	6	0.843	-0.062	4.062	0.01	0.007	0	43	37.8	76.1	134	120	0	34	32
2015	7	10	4	23	6	0.781	-0.098	4.062	0.01	0.007	0	42.1	37	76.5	133	119	0	35	33
2015	7	10	4	33	6	0.801	-0.098	4.062	0.013	0.01	0	42.6	37.8	76.1	134	120	0	35	32
2015	7	10	4	43	6	0.81	-0.089	4.062	0.01	0.007	0	42.6	37.4	76.5	133	119	0	34	32
2015	7	10	4	53	6	0.784	-0.095	4.062	0.01	0.007	0	42.1	37.8	77	133	120	0	35	32
2015	7	10	5	3	6	0.774	-0.052	4.058	0.01	0.007	0	42.6	37.8	76.5	134	120	0	35	32
2015	7	10	5	13	6	0.81	-0.066	4.058	0.016	0.013	0	42.6	37.8	76.1	134	120	0	35	32
2015	7	10	5	23	6	0.778	-0.095	4.058	0.01	0.007	0	42.6	37.8	75.3	134	120	0	35	32
2015	7	10	5	33	6	0.784	-0.089	4.055	0.016	0.013	0	43	38.3	75.7	135	121	0	35	32
2015	7	10	5	43	6	0.797	-0.049	4.055	0.013	0.01	0	43	37.8	75.7	134	120	0	34	32
2015	7	10	5	53	6	0.843	-0.098	4.052	0.01	0.007	0	42.6	38.3	74	134	120	0	35	31
2015	7	10	6	3	6	0.82	-0.079	4.052	0.01	0.007	0	43	37.8	74.4	134	120	0	34	32
2015	7	10	6	13	6	0.771	-0.079	4.052	0.01	0.007	0	43	37.8	73.5	134	120	0	34	32
2015	7	10	6	23	6	0.758	-0.085	4.049	0.01	0.007	0	43.9	37.8	72.7	136	121	0	34	33
2015	7	10	6	33	6	0.781	-0.089	4.049	0.01	0.007	0	43.4	38.7	72.7	136	122	0	35	32
2015	7	10	6	43	6	0.801	-0.095	4.045	0.01	0.007	0	43.4	38.3	73.1	135	121	0	34	32
2015	7	10	6	53	6	0.794	-0.089	4.039	0.01	0.007	0	42.6	37.8	72.2	134	120	0	35	32
2015	7	10	7	3	6	0.804	-0.089	4.035	0.01	0.007	0	43	37.8	72.7	134	120	0	34	32
2015	7	10	7	13	6	0.814	-0.075	4.032	0.01	0.007	0	42.6	37.8	73.1	134	120	0	35	32
2015	7	10	7	23	6	0.81	-0.092	4.032	0.01	0.007	0	43	37.8	74	134	120	0	34	32
2015	7	10	7	33	6	0.817	-0.102	4.032	0.01	0.007	0	42.6	37.8	73.5	134	120	0	35	32
2015	7	10	7	43	6	0.771	-0.115	4.029	0.013	0.01	0	43	37.8	74	134	120	0	34	32
2015	7	10	7	53	6	0.778	-0.082	4.029	0.016	0.013	0	43	37.8	74.8	134	120	0	34	32
2015	7	10	8	3	6	0.827	-0.108	4.029	0.013	0.01	0	42.6	38.3	74.8	134	121	0	35	32
2015	7	10	8	13	6	0.768	-0.079	4.026	0.01	0.007	0	43.4	38.7	74.8	135	122	0	34	32
2015	7	10	8	23	6	0.781	-0.075	4.026	0.013	0.01	0	43	38.7	75.7	135	122	0	35	32
2015	7	10	8	33	6	0.794	-0.085	4.026	0.013	0.01	0	43	37.8	75.3	135	121	0	35	33
2015	7	10	8	43	6	0.81	-0.098	4.026	0.013	0.01	0	43	38.3	75.7	135	121	0	35	32
2015	7	10	8	53	6	0.801	-0.108	4.022	0.013	0.01	0	43	39.1	76.5	135	122	0	35	31
2015	7	10	9	3	6	0.784	-0.112	4.022	0.01	0.007	0	43	38.3	76.1	134	121	0	34	32
2015	7	10	9	13	6	0.814	-0.095	4.022	0.01	0.007	0	43.4	38.3	76.5	135	121	0	34	32
2015	7	10	9	23	6	0.787	-0.072	4.022	0.01	0.007	0	43.4	38.3	75.7	135	121	0	34	32
2015	7	10	9	33	6	0.761	-0.098	4.022	0.016	0.013	0	42.6	38.3	76.5	134	121	0	35	32
2015	7	10	9	43	6	0.814	-0.131	4.022	0.01	0.007	0	42.6	37.8	77	133	120	0	34	32
2015	7	10	9	53	6	0.81	-0.082	4.019	0.01	0.007	0	43.4	38.7	76.1	135	122	0	34	32
2015	7	10	10	3	6	0.814	-0.079	4.019	0.01	0.007	0	42.6	37.8	76.1	134	120	0	35	32
2015	7	10	10	13	6	0.81	-0.131	4.019	0.01	0.007	0	43	37.8	75.7	134	121	0	34	33
2015	7	10	10	23	6	0.791	-0.102	4.019	0.013	0.01	0	42.1	37.8	75.3	133	120	0	35	32
2015	7	10	10	33	6	0.787	-0.089	4.016	0.013	0.01	0	42.1	37.8	75.3	133	120	0	35	32
2015	7	10	10	43	6	0.804	-0.082	4.016	0.013	0.01	0	42.6	38.3	74.8	134	121	0	35	32
2015	7	10	10	53	6	0.817	-0.128	4.016	0.013	0.01	0	42.6	37.8	73.5	134	120	0	35	32
2015	7	10	11	3	6	0.797	-0.125	4.012	0.01	0.007	0	43	38.3	73.1	135	121	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	10	11	13	6	0.814	-0.121	4.012	0.013	0.01	0	43	37.8	73.1	134	120	0	34	32
2015	7	10	11	23	6	0.764	-0.079	4.009	0.013	0.01	0	42.6	38.3	68.8	134	121	0	35	32
2015	7	10	11	33	6	0.784	-0.079	4.003	0.01	0.007	0	42.6	38.3	72.2	134	121	0	35	32
2015	7	10	11	43	6	0.797	-0.085	3.999	0.01	0.007	0	42.1	38.3	62.8	133	120	0	35	31
2015	7	10	11	53	6	0.748	-0.085	3.996	0.016	0.013	0	42.6	38.7	66.7	134	121	0	35	31
2015	7	10	12	3	6	0.791	-0.095	3.996	0.01	0.007	0	42.1	37.8	70.5	133	120	0	35	32
2015	7	10	12	13	6	0.745	-0.115	3.996	0.016	0.016	0	42.1	37.4	67.9	132	119	0	34	32
2015	7	10	12	23	6	0.787	-0.089	3.996	0.01	0.007	0	41.7	37.4	65.8	132	119	0	35	32
2015	7	10	12	33	6	0.781	-0.075	3.993	0.01	0.007	0	42.1	37.8	64.5	132	119	0	34	31
2015	7	10	12	43	6	0.768	-0.066	3.993	0.01	0.007	0	41.7	37.4	56.8	132	119	0	35	32
2015	7	10	12	53	6	0.82	-0.059	3.993	0.013	0.01	0	42.6	37.4	68.8	132	119	0	33	32
2015	7	10	13	3	6	0.784	-0.089	3.993	0.01	0.007	0	42.1	37.4	63.6	133	119	0	35	32
2015	7	10	13	13	6	0.758	-0.075	3.99	0.01	0.007	0	42.1	37.4	71	132	119	0	34	32
2015	7	10	13	23	6	0.755	-0.089	3.99	0.01	0.007	0	42.1	38.3	61.5	133	120	0	35	31
2015	7	10	13	33	6	0.787	-0.112	3.99	0.01	0.007	0	41.7	37	58.5	131	118	0	34	32
2015	7	10	13	43	6	0.741	-0.072	3.99	0.013	0.01	0	41.7	36.5	64.9	131	118	0	34	33
2015	7	10	13	53	6	0.755	-0.089	3.986	0.01	0.007	0	41.3	37	60.6	130	117	0	34	31
2015	7	10	14	3	6	0.791	-0.092	3.986	0.01	0.007	0	40.9	36.1	57.2	129	116	0	34	32
2015	7	10	14	13	6	0.748	-0.112	3.986	0.013	0.01	0	40.9	36.5	57.2	129	116	0	34	31
2015	7	10	14	23	6	0.764	-0.085	3.986	0.013	0.01	0	40.9	36.5	54.6	130	117	0	35	32
2015	7	10	14	33	6	0.738	-0.049	3.986	0.01	0.007	0	40.4	36.1	60.2	129	115	0	35	31
2015	7	10	14	43	6	0.778	-0.098	3.986	0.01	0.007	0	40.4	35.3	60.6	128	114	0	34	32
2015	7	10	14	53	6	0.705	-0.118	3.986	0.01	0.007	0	40.4	34.8	60.2	128	114	0	34	33
2015	7	10	15	3	6	0.722	-0.098	3.983	0.01	0.007	0	40.4	35.7	58.5	128	115	0	34	32
2015	7	10	15	13	6	0.709	-0.072	3.983	0.01	0.007	0	41.7	36.5	58.5	131	117	0	34	32
2015	7	10	15	23	6	0.758	-0.095	3.983	0.013	0.01	0	41.3	35.7	60.6	130	116	0	34	33
2015	7	10	15	33	6	0.758	-0.112	3.983	0.01	0.007	0	40.9	36.1	59.3	129	116	0	34	32
2015	7	10	15	43	6	0.771	-0.115	3.983	0.01	0.007	0	40.9	36.1	67.5	130	116	0	35	32
2015	7	10	15	53	6	0.814	-0.095	3.983	0.01	0.007	0	40.9	36.1	63.2	130	116	0	35	32
2015	7	10	16	3	6	0.764	-0.095	3.983	0.01	0.007	0	41.3	36.1	68.4	130	116	0	34	32
2015	7	10	16	13	6	0.791	-0.062	3.983	0.01	0.007	0	41.3	36.1	75.7	130	116	0	34	32
2015	7	10	16	23	6	0.784	-0.082	3.983	0.01	0.007	0	41.3	36.5	71	131	117	0	35	32
2015	7	10	16	33	6	0.741	-0.082	3.983	0.01	0.007	0	41.7	36.5	58.5	131	117	0	34	32
2015	7	10	16	43	6	0.758	-0.095	3.983	0.01	0.007	0	42.6	37.4	64.5	133	119	0	34	32
2015	7	10	16	53	6	0.804	-0.082	3.98	0.01	0.007	0	43	37.4	56.3	134	119	0	34	32
2015	7	10	17	3	6	0.797	-0.102	3.983	0.01	0.007	0	43	38.3	64.5	135	121	0	35	32
2015	7	10	17	13	6	0.804	-0.092	3.98	0.01	0.007	0	43.9	38.7	69.2	136	122	0	34	32
2015	7	10	17	23	6	0.797	-0.075	3.98	0.01	0.007	0	43	38.7	61.5	135	121	0	35	31
2015	7	10	17	33	6	0.771	-0.082	3.98	0.01	0.007	0	43.4	38.3	65.8	135	121	0	34	32
2015	7	10	17	43	6	0.794	-0.079	3.98	0.013	0.01	0	43.4	38.7	63.2	135	121	0	34	31
2015	7	10	17	53	6	0.758	-0.085	3.98	0.01	0.007	0	42.6	37.4	73.5	133	119	0	34	32
2015	7	10	18	3	6	0.758	-0.082	3.98	0.01	0.007	0	42.6	37.4	73.5	133	119	0	34	32
2015	7	10	18	13	6	0.735	-0.082	3.98	0.01	0.007	0	42.1	37	72.2	132	118	0	34	32
2015	7	10	18	23	6	0.807	-0.052	3.98	0.01	0.007	0	41.7	36.5	73.5	131	117	0	34	32
2015	7	10	18	33	6	0.804	-0.079	3.98	0.01	0.007	0	41.7	36.5	73.1	131	117	0	34	32
2015	7	10	18	43	6	0.774	-0.056	3.98	0.01	0.007	0	41.3	37	72.7	131	117	0	35	31
2015	7	10	18	53	6	0.791	-0.095	3.98	0.01	0.007	0	41.3	36.5	73.5	131	117	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	10	19	3	6	0.768	-0.062	3.98	0.01	0.007	0	41.7	36.5	74.8	131	117	0	34	32
2015	7	10	19	13	6	0.768	-0.082	3.98	0.01	0.007	0	41.3	36.5	74.4	130	116	0	34	31
2015	7	10	19	23	6	0.778	-0.082	3.98	0.01	0.007	0	41.7	36.1	74.4	131	116	0	34	32
2015	7	10	19	33	6	0.797	-0.095	3.98	0.01	0.007	0	40.9	36.1	74.4	131	116	0	36	32
2015	7	10	19	43	6	0.781	-0.079	3.98	0.01	0.007	0	41.3	36.1	75.3	130	116	0	34	32
2015	7	10	19	53	6	0.784	-0.089	3.98	0.01	0.007	0	40.9	35.7	75.7	130	115	0	35	32
2015	7	10	20	3	6	0.768	-0.095	3.983	0.016	0.013	0	41.3	36.5	75.3	131	117	0	35	32
2015	7	10	20	13	6	0.778	-0.079	3.983	0.01	0.007	0	41.3	37	75.7	131	117	0	35	31
2015	7	10	20	23	6	0.787	-0.069	3.983	0.016	0.016	0	41.3	36.5	74.8	131	117	0	35	32
2015	7	10	20	33	6	0.827	-0.108	3.983	0.01	0.007	0	42.1	37	75.7	132	118	0	34	32
2015	7	10	20	43	6	0.801	-0.072	3.983	0.013	0.01	0	41.7	37	74.4	132	118	0	35	32
2015	7	10	20	53	6	0.791	-0.092	3.983	0.01	0.007	0	41.7	36.5	75.3	131	117	0	34	32
2015	7	10	21	3	6	0.797	-0.075	3.983	0.01	0.007	0	41.3	36.5	75.7	130	116	0	34	31
2015	7	10	21	13	6	0.764	-0.118	3.983	0.01	0.007	0	40.9	36.1	76.5	130	116	0	35	32
2015	7	10	21	23	6	0.771	-0.075	3.986	0.01	0.007	0	41.3	36.5	76.1	131	116	0	35	31
2015	7	10	21	33	6	0.732	-0.075	3.983	0.01	0.007	0	41.7	37	77.4	132	118	0	35	32
2015	7	10	21	43	6	0.794	-0.112	3.986	0.01	0.007	0	41.3	37	76.1	131	117	0	35	31
2015	7	10	21	53	6	0.814	-0.125	3.986	0.013	0.01	0	41.7	36.5	77	131	117	0	34	32
2015	7	10	22	3	6	0.804	-0.118	3.986	0.01	0.007	0	41.7	37	77.4	132	118	0	35	32
2015	7	10	22	13	6	0.791	-0.092	3.986	0.013	0.01	0	42.1	36.5	76.5	132	117	0	34	32
2015	7	10	22	23	6	0.741	-0.128	3.986	0.01	0.007	0	42.1	36.5	77	132	117	0	34	32
2015	7	10	22	33	6	0.787	-0.098	3.986	0.01	0.007	0	41.7	37	77	132	117	0	35	31
2015	7	10	22	43	6	0.794	-0.112	3.986	0.01	0.007	0	41.3	36.5	77	131	117	0	35	32
2015	7	10	22	53	6	0.82	-0.075	3.986	0.01	0.007	0	41.3	36.5	77	131	117	0	35	32
2015	7	10	23	3	6	0.732	-0.082	3.986	0.01	0.007	0	42.1	37	76.5	132	118	0	34	32
2015	7	10	23	13	6	0.758	-0.082	3.986	0.01	0.007	0	41.7	37	67.9	132	118	0	35	32
2015	7	10	23	23	6	0.833	-0.092	3.99	0.01	0.007	0	42.1	37	76.5	132	118	0	34	32
2015	7	10	23	33	6	0.85	-0.105	3.986	0.01	0.007	0	42.1	37	73.5	132	118	0	34	32
2015	7	10	23	43	6	0.791	-0.102	3.99	0.01	0.007	0	41.7	36.5	76.5	132	117	0	35	32
2015	7	10	23	53	6	0.771	-0.075	3.99	0.01	0.007	0	42.1	37	76.5	132	118	0	34	32
2015	7	11	0	3	6	0.797	-0.102	3.99	0.01	0.007	0	41.7	36.5	76.5	132	117	0	35	32
2015	7	11	0	13	6	0.758	-0.069	3.99	0.013	0.01	0	42.1	37	76.1	132	118	0	34	32
2015	7	11	0	23	6	0.755	-0.085	3.99	0.01	0.007	0	42.1	36.5	76.1	132	117	0	34	32
2015	7	11	0	33	6	0.794	-0.115	3.99	0.013	0.01	0	41.7	36.5	76.5	131	117	0	34	32
2015	7	11	0	43	6	0.827	-0.082	3.99	0.01	0.007	0	41.3	36.5	76.1	131	117	0	35	32
2015	7	11	0	53	6	0.764	-0.102	3.99	0.01	0.007	0	41.7	36.1	76.1	132	117	0	35	33
2015	7	11	1	3	6	0.794	-0.062	3.99	0.016	0.013	0	41.7	36.5	75.3	132	117	0	35	32
2015	7	11	1	13	6	0.797	-0.079	3.993	0.01	0.007	0	41.7	36.5	76.1	132	117	0	35	32
2015	7	11	1	23	6	0.787	-0.072	3.993	0.01	0.007	0	41.7	36.5	75.3	131	117	0	34	32
2015	7	11	1	33	6	0.84	-0.125	3.993	0.01	0.007	0	41.7	36.5	74.8	131	117	0	34	32
2015	7	11	1	43	6	0.774	-0.108	3.993	0.01	0.007	0	41.3	36.5	73.5	131	117	0	35	32
2015	7	11	1	53	6	0.758	-0.069	3.993	0.013	0.01	0	42.1	37	74.4	132	118	0	34	32
2015	7	11	2	3	6	0.804	-0.082	3.993	0.013	0.01	0	41.7	37	74.8	132	118	0	35	32
2015	7	11	2	13	6	0.768	-0.095	3.996	0.01	0.007	0	41.7	37	73.5	132	118	0	35	32
2015	7	11	2	23	6	0.794	-0.112	3.996	0.01	0.007	0	42.1	37	73.5	132	118	0	34	32
2015	7	11	2	33	6	0.817	-0.079	3.996	0.013	0.01	0	42.6	37	74	133	118	0	34	32
2015	7	11	2	43	6	0.817	-0.125	3.996	0.013	0.01	0	42.1	37	74	132	118	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	11	2	53	6	0.778	-0.115	3.996	0.013	0.01	0	42.6	37	73.5	133	118	0	34	32
2015	7	11	3	3	6	0.814	-0.085	3.996	0.013	0.01	0	42.6	37.4	73.1	133	119	0	34	32
2015	7	11	3	13	6	0.781	-0.095	3.999	0.01	0.007	0	42.1	36.5	72.2	132	118	0	34	33
2015	7	11	3	23	6	0.837	-0.098	3.999	0.01	0.007	0	42.6	37.4	72.7	133	119	0	34	32
2015	7	11	3	33	6	0.758	-0.079	4.006	0.01	0.007	0	42.6	37	71.8	133	119	0	34	33
2015	7	11	3	43	6	0.823	-0.108	4.009	0.01	0.007	0	42.1	37.8	72.7	133	119	0	35	31
2015	7	11	3	53	6	0.778	-0.115	4.009	0.01	0.007	0	42.6	37.8	74	134	119	0	35	31
2015	7	11	4	3	6	0.804	-0.098	4.009	0.01	0.007	0	42.6	37	74	133	119	0	34	33
2015	7	11	4	13	6	0.781	-0.085	4.012	0.013	0.01	0	42.1	37.4	74	133	119	0	35	32
2015	7	11	4	23	6	0.781	-0.121	4.012	0.013	0.01	0	42.1	37.4	73.5	133	119	0	35	32
2015	7	11	4	33	6	0.794	-0.089	4.012	0.01	0.007	0	42.6	37.4	74.8	133	119	0	34	32
2015	7	11	4	43	6	0.801	-0.079	4.012	0.013	0.01	0	43	38.3	74.8	134	120	0	34	31
2015	7	11	4	53	6	0.801	-0.095	4.012	0.01	0.007	0	43	37.8	74.8	134	120	0	34	32
2015	7	11	5	3	6	0.823	-0.095	4.012	0.013	0.01	0	42.6	37.8	75.3	134	120	0	35	32
2015	7	11	5	13	6	0.787	-0.098	4.016	0.01	0.007	0	42.6	37.8	75.3	134	120	0	35	32
2015	7	11	5	23	6	0.827	-0.098	4.016	0.01	0.007	0	42.6	37.4	76.1	134	120	0	35	33
2015	7	11	5	33	6	0.774	-0.108	4.016	0.01	0.007	0	42.6	37.8	76.1	134	120	0	35	32
2015	7	11	5	43	6	0.814	-0.105	4.016	0.01	0.007	0	43	37.8	76.1	134	120	0	34	32
2015	7	11	5	53	6	0.801	-0.108	4.016	0.013	0.01	0	42.6	38.3	77	134	120	0	35	31
2015	7	11	6	3	6	0.82	-0.125	4.016	0.013	0.01	0	42.6	38.3	76.5	134	120	0	35	31
2015	7	11	6	13	6	0.761	-0.079	4.016	0.01	0.007	0	42.6	38.3	76.5	134	120	0	35	31
2015	7	11	6	23	6	0.827	-0.092	4.016	0.013	0.01	0	42.1	37.4	77	133	119	0	35	32
2015	7	11	6	33	6	0.807	-0.092	4.019	0.013	0.01	0	42.1	37.4	76.5	133	119	0	35	32
2015	7	11	6	43	6	0.801	-0.085	4.019	0.01	0.007	0	42.1	37.4	77	133	119	0	35	32
2015	7	11	6	53	6	0.817	-0.092	4.016	0.01	0.007	0	42.1	37	76.1	132	118	0	34	32
2015	7	11	7	3	6	0.771	-0.089	4.019	0.01	0.007	0	42.6	37.4	76.5	133	119	0	34	32
2015	7	11	7	13	6	0.817	-0.118	4.019	0.01	0.007	0	42.1	37	76.5	132	118	0	34	32
2015	7	11	7	23	6	0.797	-0.079	4.019	0.013	0.01	0	41.7	37	76.5	132	118	0	35	32
2015	7	11	7	33	6	0.787	-0.105	4.019	0.01	0.007	0	41.3	36.5	75.7	131	117	0	35	32
2015	7	11	7	43	6	0.771	-0.105	4.019	0.013	0.01	0	42.1	37	76.1	132	118	0	34	32
2015	7	11	7	53	6	0.761	-0.098	4.019	0.01	0.007	0	42.1	37	76.1	132	118	0	34	32
2015	7	11	8	3	6	0.781	-0.095	4.019	0.013	0.01	0	42.1	37.4	76.1	133	119	0	35	32
2015	7	11	8	13	6	0.807	-0.112	4.019	0.013	0.01	0	41.7	37.4	75.3	132	119	0	35	32
2015	7	11	8	23	6	0.761	-0.098	4.019	0.01	0.007	0	43	38.3	75.3	135	121	0	35	32
2015	7	11	8	33	6	0.823	-0.079	4.019	0.01	0.007	0	42.6	37.8	76.1	134	121	0	35	33
2015	7	11	8	43	6	0.801	-0.095	4.022	0.01	0.007	0	42.6	37.4	76.5	134	120	0	35	33
2015	7	11	8	53	6	0.801	-0.085	4.022	0.01	0.007	0	42.6	38.7	75.7	134	121	0	35	31
2015	7	11	9	3	6	0.827	-0.128	4.022	0.016	0.013	0	42.6	38.3	75.7	134	121	0	35	32
2015	7	11	9	13	6	0.81	-0.092	4.022	0.013	0.01	0	43.9	38.7	75.7	136	122	0	34	32
2015	7	11	9	23	6	0.794	-0.108	4.022	0.013	0.01	0	43.4	38.7	75.7	135	122	0	34	32
2015	7	11	9	33	6	0.801	-0.079	4.022	0.01	0.007	0	43	37.8	75.3	135	121	0	35	33
2015	7	11	9	43	6	0.794	-0.089	4.022	0.01	0.007	0	43	38.7	74.8	135	122	0	35	32
2015	7	11	9	53	6	0.804	-0.089	4.026	0.013	0.01	0	42.6	37.8	74.4	134	121	0	35	33
2015	7	11	10	3	6	0.82	-0.092	4.026	0.013	0.01	0	43	37.8	74.8	134	121	0	34	33
2015	7	11	10	13	6	0.787	-0.089	4.026	0.01	0.007	0	42.1	37	75.3	133	119	0	35	33
2015	7	11	10	23	6	0.778	-0.105	4.026	0.01	0.007	0	42.6	38.3	75.3	133	120	0	34	31
2015	7	11	10	33	6	0.81	-0.092	4.026	0.013	0.01	0	43.4	38.7	71.4	136	122	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	11	10	43	6	0.778	-0.079	4.026	0.01	0.007	0	43.4	39.1	71.8	136	123	0	35	32
2015	7	11	10	53	6	0.801	-0.118	4.026	0.016	0.013	0	43	38.7	66.2	135	122	0	35	32
2015	7	11	11	3	6	0.732	-0.121	4.026	0.01	0.007	0	43	38.7	71	135	122	0	35	32
2015	7	11	11	13	6	0.794	-0.098	4.026	0.01	0.007	0	43.9	38.3	58.5	136	122	0	34	33
2015	7	11	11	23	6	0.764	-0.079	4.026	0.01	0.007	0	43.4	38.7	64.5	135	121	0	34	31
2015	7	11	11	33	6	0.732	-0.108	4.029	0.013	0.01	0	43.4	38.7	55	136	122	0	35	32
2015	7	11	11	43	6	0.761	-0.082	4.029	0.01	0.007	0	43.4	38.7	57.2	136	122	0	35	32
2015	7	11	11	53	6	0.741	-0.108	4.029	0.01	0.007	0	43.9	39.1	57.6	136	123	0	34	32
2015	7	11	12	3	6	0.764	-0.112	4.029	0.01	0.007	0	43.9	38.7	59.8	136	122	0	34	32
2015	7	11	12	13	6	0.751	-0.082	4.029	0.01	0.007	0	43.4	39.1	59.8	136	123	0	35	32
2015	7	11	12	23	6	0.797	-0.092	4.029	0.013	0.01	0	43.4	38.7	58	136	122	0	35	32
2015	7	11	12	33	6	0.751	-0.092	4.029	0.013	0.01	0	44.3	39.1	56.3	137	123	0	34	32
2015	7	11	12	43	6	0.814	-0.092	4.029	0.013	0.01	0	43.4	38.7	64.1	136	122	0	35	32
2015	7	11	12	53	6	0.781	-0.092	4.029	0.01	0.007	0	43	38.3	64.1	135	121	0	35	32
2015	7	11	13	3	6	0.761	-0.089	4.029	0.01	0.007	0	44.3	39.6	64.1	138	124	0	35	32
2015	7	11	13	13	6	0.758	-0.069	4.029	0.01	0.007	0	43.9	39.1	58.5	136	123	0	34	32
2015	7	11	13	23	6	0.804	-0.125	4.029	0.01	0.007	0	43	38.7	63.2	135	122	0	35	32
2015	7	11	13	33	6	0.781	-0.112	4.029	0.01	0.007	0	43.4	38.7	55.9	135	122	0	34	32
2015	7	11	13	43	6	0.738	-0.105	4.029	0.013	0.01	0	43.9	38.7	55	136	122	0	34	32
2015	7	11	13	53	6	0.814	-0.079	4.029	0.016	0.013	0	44.3	39.1	56.8	137	123	0	34	32
2015	7	11	14	3	6	0.768	-0.079	4.029	0.016	0.013	0	43.9	39.6	53.3	137	123	0	35	31
2015	7	11	14	13	6	0.768	-0.128	4.029	0.01	0.007	0	43.4	39.1	54.6	135	122	0	34	31
2015	7	11	14	23	6	0.784	-0.095	4.029	0.013	0.01	0	43.9	38.7	50.3	136	122	0	34	32
2015	7	11	14	33	6	0.774	-0.102	4.029	0.016	0.016	0	44.3	39.1	52	137	123	0	34	32
2015	7	11	14	43	6	0.787	-0.079	4.029	0.01	0.007	0	43	37.8	51.6	135	121	0	35	33
2015	7	11	14	53	6	0.764	-0.059	4.029	0.013	0.01	0	44.7	39.6	51.6	138	124	0	34	32
2015	7	11	15	3	6	0.774	-0.092	4.029	0.01	0.007	0	43	38.3	50.3	135	121	0	35	32
2015	7	11	15	13	6	0.81	-0.105	4.029	0.013	0.01	0	46	40.4	50.3	141	126	0	34	32
2015	7	11	15	23	6	0.83	-0.102	4.026	0.01	0.007	0	43	38.3	53.3	134	121	0	34	32
2015	7	11	15	33	6	0.755	-0.105	4.029	0.01	0.007	0	43	38.3	55.5	134	121	0	34	32
2015	7	11	15	43	6	0.761	-0.079	4.029	0.01	0.007	0	42.1	37.8	52.9	133	120	0	35	32
2015	7	11	15	53	6	0.755	-0.072	4.029	0.013	0.01	0	43.9	39.6	51.2	137	124	0	35	32
2015	7	11	16	3	6	0.758	-0.102	4.029	0.013	0.01	0	44.3	40	52	137	125	0	34	32
2015	7	11	16	13	6	0.771	-0.092	4.029	0.013	0.01	0	43.4	39.1	54.2	135	122	0	34	31
2015	7	11	16	23	6	0.751	-0.072	4.026	0.013	0.01	0	48.2	44.3	44.7	146	135	0	34	32
2015	7	11	16	33	6	0.774	-0.079	4.029	0.013	0.01	0	43	37.8	52.5	134	120	0	34	32
2015	7	11	16	43	6	0.758	-0.062	4.029	0.01	0.007	0	47.7	40.4	45.2	145	126	0	34	32
2015	7	11	16	53	6	0.755	-0.118	4.026	0.01	0.007	0	44.7	38.3	46.9	138	121	0	34	32
2015	7	11	17	3	6	0.768	-0.072	4.029	0.013	0.01	0	47.3	42.1	48.6	144	130	0	34	32
2015	7	11	17	13	6	0.797	-0.102	4.029	0.013	0.01	0	42.6	37.4	53.8	134	119	0	35	32
2015	7	11	17	23	6	0.771	-0.128	4.029	0.01	0.007	0	43	37.8	58	134	119	0	34	31
2015	7	11	17	33	6	0.709	-0.082	4.032	0.016	0.013	0	43	37.8	55	134	120	0	34	32
2015	7	11	17	43	6	0.761	-0.115	4.032	0.01	0.007	0	42.6	37.4	55.9	134	119	0	35	32
2015	7	11	17	53	6	0.797	-0.108	4.029	0.013	0.01	0	42.6	37	59.8	133	118	0	34	32
2015	7	11	18	3	6	0.738	-0.112	4.032	0.01	0.007	0	43	37.4	64.1	134	119	0	34	32
2015	7	11	18	13	6	0.768	-0.089	4.032	0.013	0.01	0	42.6	37.4	59.8	134	119	0	35	32
2015	7	11	18	23	6	0.755	-0.112	4.032	0.013	0.01	0	42.6	37.4	55.9	134	119	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	11	18	33	6	0.745	-0.079	4.032	0.013	0.01	0	42.6	37.8	54.6	134	120	0	35	32
2015	7	11	18	43	6	0.725	-0.102	4.032	0.01	0.007	0	42.6	37.8	61.1	134	119	0	35	31
2015	7	11	18	53	6	0.741	-0.089	4.035	0.013	0.01	0	42.1	37.4	55.5	133	119	0	35	32
2015	7	11	19	3	6	0.764	-0.092	4.032	0.013	0.01	0	43	37.8	66.2	134	120	0	34	32
2015	7	11	19	13	6	0.738	-0.082	4.035	0.01	0.007	0	42.6	37.4	54.6	134	119	0	35	32
2015	7	11	19	23	6	0.768	-0.105	4.035	0.016	0.013	0	43	37.4	56.3	134	120	0	34	33
2015	7	11	19	33	6	0.741	-0.098	4.035	0.013	0.01	0	43.4	38.7	58	136	122	0	35	32
2015	7	11	19	43	6	0.732	-0.118	4.035	0.01	0.007	0	43.4	38.7	57.2	136	122	0	35	32
2015	7	11	19	53	6	0.741	-0.092	4.039	0.01	0.007	0	43.4	39.1	66.2	136	123	0	35	32
2015	7	11	20	3	6	0.774	-0.066	4.039	0.013	0.01	0	44.3	39.1	65.8	137	123	0	34	32
2015	7	11	20	13	6	0.787	-0.102	4.039	0.013	0.01	0	43.9	39.1	64.1	137	123	0	35	32
2015	7	11	20	23	6	0.741	-0.098	4.042	0.013	0.01	0	43.9	38.7	56.3	136	122	0	34	32
2015	7	11	20	33	6	0.768	-0.089	4.042	0.013	0.01	0	43.4	38.3	62.4	136	121	0	35	32
2015	7	11	20	43	6	0.738	-0.128	4.049	0.01	0.007	0	44.3	38.7	64.9	137	122	0	34	32
2015	7	11	20	53	6	0.791	-0.108	4.049	0.01	0.007	0	43.9	38.7	60.6	136	122	0	34	32
2015	7	11	21	3	6	0.755	-0.108	4.052	0.01	0.007	0	43.4	38.7	60.6	136	122	0	35	32
2015	7	11	21	13	6	0.755	-0.112	4.055	0.01	0.007	0	43.9	38.3	59.3	136	121	0	34	32
2015	7	11	21	23	6	0.745	-0.072	4.052	0.01	0.007	0	43.4	37.8	57.6	135	120	0	34	32
2015	7	11	21	33	6	0.771	-0.138	4.058	0.01	0.007	0	42.6	37.8	61.5	134	120	0	35	32
2015	7	11	21	43	6	0.794	-0.062	4.058	0.01	0.007	0	42.6	37.4	63.2	134	119	0	35	32
2015	7	11	21	53	6	0.758	-0.112	4.058	0.013	0.01	0	42.6	37.8	63.2	134	120	0	35	32
2015	7	11	22	3	6	0.745	-0.082	4.062	0.01	0.007	0	42.6	37.4	67.5	133	119	0	34	32
2015	7	11	22	13	6	0.738	-0.075	4.062	0.016	0.013	0	42.6	37	67.5	133	118	0	34	32
2015	7	11	22	23	6	0.771	-0.118	4.062	0.013	0.01	0	43	37.4	61.9	134	119	0	34	32
2015	7	11	22	33	6	0.778	-0.062	4.065	0.01	0.007	0	43	37.4	74	134	118	0	34	31
2015	7	11	22	43	6	0.758	-0.082	4.065	0.016	0.013	0	42.6	37	75.3	134	118	0	35	32
2015	7	11	22	53	6	0.758	-0.049	4.065	0.01	0.007	0	43	37	75.3	134	118	0	34	32
2015	7	11	23	3	6	0.804	-0.082	4.065	0.013	0.01	0	42.6	36.1	76.1	133	117	0	34	33
2015	7	11	23	13	6	0.768	-0.098	4.065	0.01	0.007	0	42.1	37	75.3	133	118	0	35	32
2015	7	11	23	23	6	0.791	-0.102	4.065	0.016	0.013	0	43	37.4	67.9	134	119	0	34	32
2015	7	11	23	33	6	0.758	-0.102	4.068	0.01	0.007	0	42.6	37.8	74.8	134	119	0	35	31
2015	7	11	23	43	6	0.741	-0.066	4.068	0.01	0.007	0	43	37.4	75.3	134	119	0	34	32
2015	7	11	23	53	6	0.771	-0.082	4.068	0.01	0.007	0	42.6	37.4	75.7	134	119	0	35	32
2015	7	12	0	3	6	0.791	-0.075	4.068	0.013	0.01	0	42.6	37	75.7	134	118	0	35	32
2015	7	12	0	13	6	0.804	-0.112	4.072	0.01	0.007	0	42.6	37	75.3	134	119	0	35	33
2015	7	12	0	23	6	0.797	-0.102	4.072	0.013	0.01	0	43	37.4	74	134	119	0	34	32
2015	7	12	0	33	6	0.755	-0.089	4.072	0.01	0.007	0	43	37.4	73.1	134	119	0	34	32
2015	7	12	0	43	6	0.771	-0.075	4.072	0.01	0.007	0	42.6	37.4	74.4	134	119	0	35	32
2015	7	12	0	53	6	0.791	-0.112	4.075	0.013	0.01	0	42.6	37.4	73.1	134	119	0	35	32
2015	7	12	1	3	6	0.807	-0.118	4.075	0.01	0.007	0	42.6	37.4	73.5	134	119	0	35	32
2015	7	12	1	13	6	0.745	-0.066	4.075	0.013	0.01	0	43	37.4	73.5	134	119	0	34	32
2015	7	12	1	23	6	0.787	-0.075	4.078	0.01	0.007	0	42.6	37	72.7	133	118	0	34	32
2015	7	12	1	33	6	0.823	-0.092	4.078	0.013	0.01	0	42.6	37	72.7	133	118	0	34	32
2015	7	12	1	43	6	0.787	-0.092	4.085	0.016	0.013	0	43	37.4	71.8	134	119	0	34	32
2015	7	12	1	53	6	0.804	-0.066	4.088	0.01	0.007	0	43	37.4	72.7	134	119	0	34	32
2015	7	12	2	3	6	0.837	-0.082	4.091	0.01	0.007	0	43	37.4	73.1	134	119	0	34	32
2015	7	12	2	13	6	0.801	-0.066	4.091	0.01	0.007	0	43	37	74	134	118	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	12	2	23	6	0.804	-0.112	4.094	0.01	0.007	0	42.6	37.4	73.1	133	119	0	34	32
2015	7	12	2	33	6	0.817	-0.098	4.094	0.01	0.007	0	42.6	37.4	74	134	119	0	35	32
2015	7	12	2	43	6	0.843	-0.105	4.094	0.01	0.007	0	42.6	37.8	75.3	133	119	0	34	31
2015	7	12	2	53	6	0.827	-0.108	4.098	0.01	0.007	0	42.1	37.4	75.3	133	119	0	35	32
2015	7	12	3	3	6	0.784	-0.079	4.098	0.01	0.007	0	43	37.4	76.1	134	119	0	34	32
2015	7	12	3	13	6	0.787	-0.075	4.098	0.013	0.01	0	42.6	37	76.1	133	118	0	34	32
2015	7	12	3	23	6	0.827	-0.108	4.101	0.01	0.007	0	43	37	76.5	134	119	0	34	33
2015	7	12	3	33	6	0.843	-0.108	4.101	0.01	0.007	0	42.6	37.8	76.5	134	119	0	35	31
2015	7	12	3	43	6	0.85	-0.108	4.101	0.01	0.007	0	43	37.4	76.5	134	119	0	34	32
2015	7	12	3	53	6	0.751	-0.075	4.101	0.01	0.007	0	43	37.4	77	134	119	0	34	32
2015	7	12	4	3	6	0.843	-0.098	4.101	0.01	0.007	0	42.6	37.4	76.5	133	119	0	34	32
2015	7	12	4	13	6	0.804	-0.056	4.101	0.013	0.01	0	43	37.4	76.1	134	119	0	34	32
2015	7	12	4	23	6	0.801	-0.079	4.101	0.01	0.007	0	43	37.4	77	134	119	0	34	32
2015	7	12	4	33	6	0.784	-0.085	4.104	0.01	0.007	0	43	37.4	75.7	134	119	0	34	32
2015	7	12	4	43	6	0.833	-0.082	4.104	0.01	0.007	0	43.4	37.8	76.1	135	120	0	34	32
2015	7	12	4	53	6	0.784	-0.108	4.104	0.01	0.007	0	43	37.4	75.7	134	119	0	34	32
2015	7	12	5	3	6	0.804	-0.072	4.104	0.01	0.007	0	43	37.8	75.7	134	119	0	34	31
2015	7	12	5	13	6	0.83	-0.092	4.104	0.01	0.007	0	43	37.8	74.8	134	120	0	34	32
2015	7	12	5	23	6	0.791	-0.059	4.104	0.01	0.007	0	43.4	37.8	74.8	135	120	0	34	32
2015	7	12	5	33	6	0.817	-0.092	4.104	0.01	0.007	0	43	37.8	74.4	135	120	0	35	32
2015	7	12	5	43	6	0.817	-0.089	4.108	0.013	0.01	0	42.6	37.4	74.8	134	119	0	35	32
2015	7	12	5	53	6	0.814	-0.079	4.108	0.01	0.007	0	43.4	37.8	74.8	135	120	0	34	32
2015	7	12	6	3	6	0.833	-0.075	4.108	0.01	0.007	0	42.6	37.8	73.5	134	119	0	35	31
2015	7	12	6	13	6	0.797	-0.059	4.108	0.016	0.013	0	42.6	37.4	74.8	134	119	0	35	32
2015	7	12	6	23	6	0.833	-0.069	4.108	0.01	0.007	0	42.6	37.4	74	134	119	0	35	32
2015	7	12	6	33	6	0.797	-0.069	4.108	0.01	0.007	0	43.4	37.8	73.5	135	120	0	34	32
2015	7	12	6	43	6	0.787	-0.092	4.111	0.01	0.007	0	43	37.8	74	135	120	0	35	32
2015	7	12	6	53	6	0.791	-0.079	4.111	0.01	0.007	0	42.6	37.8	74	134	120	0	35	32
2015	7	12	7	3	6	0.817	-0.135	4.111	0.01	0.007	0	42.6	37.8	73.1	134	120	0	35	32
2015	7	12	7	13	6	0.794	-0.082	4.111	0.013	0.01	0	43	37.8	72.7	134	120	0	34	32
2015	7	12	7	23	6	0.82	-0.089	4.114	0.01	0.007	0	42.6	37.4	71.4	133	119	0	34	32
2015	7	12	7	33	6	0.768	-0.069	4.117	0.01	0.007	0	42.1	37.4	71.8	133	119	0	35	32
2015	7	12	7	43	6	0.814	-0.072	4.121	0.01	0.007	0	42.6	37.4	72.7	133	119	0	34	32
2015	7	12	7	53	6	0.82	-0.082	4.124	0.016	0.013	0	43	37.8	72.2	134	120	0	34	32
2015	7	12	8	3	6	0.791	-0.112	4.124	0.013	0.01	0	43	37.8	72.2	135	121	0	35	33
2015	7	12	8	13	6	0.814	-0.108	4.127	0.013	0.01	0	43.4	38.3	73.1	136	121	0	35	32
2015	7	12	8	23	6	0.778	-0.095	4.127	0.013	0.01	0	43	38.3	73.5	135	121	0	35	32
2015	7	12	8	33	6	0.833	-0.092	4.127	0.013	0.01	0	43	38.3	73.1	135	121	0	35	32
2015	7	12	8	43	6	0.843	-0.075	4.127	0.01	0.007	0	43	37.8	74	135	121	0	35	33
2015	7	12	8	53	6	0.801	-0.085	4.127	0.01	0.007	0	43	38.7	73.5	135	122	0	35	32
2015	7	12	9	3	6	0.833	-0.112	4.127	0.01	0.007	0	42.6	37.8	74.4	134	120	0	35	32
2015	7	12	9	13	6	0.791	-0.069	4.131	0.01	0.007	0	43	38.3	74	134	120	0	34	31
2015	7	12	9	23	6	0.794	-0.089	4.131	0.013	0.01	0	43	37.8	74.4	134	120	0	34	32
2015	7	12	9	33	6	0.781	-0.095	4.131	0.01	0.007	0	42.6	38.3	74.4	134	120	0	35	31
2015	7	12	9	43	6	0.84	-0.092	4.131	0.016	0.016	0	43	37.8	74	134	120	0	34	32
2015	7	12	9	53	6	0.82	-0.105	4.131	0.01	0.007	0	42.6	37.8	74.8	134	120	0	35	32
2015	7	12	10	3	6	0.791	-0.085	4.131	0.01	0.007	0	43	37.8	74.8	134	120	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	12	10	13	6	0.83	-0.125	4.131	0.01	0.007	0	42.1	37.4	67.5	133	119	0	35	32
2015	7	12	10	23	6	0.768	-0.085	4.131	0.01	0.007	0	43	37.8	61.9	134	120	0	34	32
2015	7	12	10	33	6	0.797	-0.089	4.134	0.01	0.007	0	43	37.8	74	134	120	0	34	32
2015	7	12	10	43	6	0.817	-0.092	4.131	0.01	0.007	0	42.1	37.8	59.8	133	119	0	35	31
2015	7	12	10	53	6	0.814	-0.092	4.131	0.016	0.013	0	43	37.8	66.2	134	120	0	34	32
2015	7	12	11	3	6	0.748	-0.095	4.131	0.01	0.007	0	42.1	37.4	58.5	133	119	0	35	32
2015	7	12	11	13	6	0.804	-0.098	4.131	0.01	0.007	0	43	37.8	60.6	135	120	0	35	32
2015	7	12	11	23	6	0.768	-0.095	4.131	0.01	0.007	0	42.6	37.8	55.9	134	120	0	35	32
2015	7	12	11	33	6	0.764	-0.085	4.131	0.01	0.007	0	42.6	37.8	59.8	134	120	0	35	32
2015	7	12	11	43	6	0.787	-0.092	4.131	0.01	0.007	0	42.6	38.3	58.5	134	120	0	35	31
2015	7	12	11	53	6	0.755	-0.105	4.134	0.013	0.01	0	42.6	37.8	67.5	134	120	0	35	32
2015	7	12	12	3	6	0.801	-0.102	4.134	0.013	0.01	0	42.6	37.8	64.1	133	119	0	34	31
2015	7	12	12	13	6	0.81	-0.092	4.134	0.01	0.007	0	41.7	37	67.1	132	118	0	35	32
2015	7	12	12	23	6	0.804	-0.105	4.134	0.01	0.007	0	41.7	37.4	64.1	132	118	0	35	31
2015	7	12	12	33	6	0.751	-0.082	4.131	0.01	0.007	0	42.6	37.8	59.3	133	119	0	34	31
2015	7	12	12	43	6	0.768	-0.072	4.131	0.01	0.007	0	42.1	37.4	54.6	132	119	0	34	32
2015	7	12	12	53	6	0.771	-0.098	4.131	0.01	0.007	0	41.3	36.5	58.9	131	117	0	35	32
2015	7	12	13	3	6	0.751	-0.095	4.131	0.013	0.01	0	41.3	37	53.8	131	117	0	35	31
2015	7	12	13	13	6	0.784	-0.095	4.131	0.01	0.007	0	41.3	36.1	55	131	117	0	35	33
2015	7	12	13	23	6	0.833	-0.089	4.131	0.01	0.007	0	42.1	37	56.3	132	117	0	34	31
2015	7	12	13	33	6	0.755	-0.108	4.131	0.01	0.007	0	42.6	37.4	54.6	133	119	0	34	32
2015	7	12	13	43	6	0.794	-0.112	4.131	0.016	0.013	0	42.1	37.4	52	133	119	0	35	32
2015	7	12	13	53	6	0.768	-0.105	4.127	0.01	0.007	0	42.6	37.4	54.6	133	119	0	34	32
2015	7	12	14	3	6	0.787	-0.112	4.127	0.01	0.007	0	43	38.3	53.8	134	121	0	34	32
2015	7	12	14	13	6	0.801	-0.121	4.127	0.01	0.007	0	43	37.4	54.6	134	120	0	34	33
2015	7	12	14	23	6	0.807	-0.082	4.127	0.013	0.01	0	42.6	37.8	49.9	134	120	0	35	32
2015	7	12	14	33	6	0.764	-0.082	4.127	0.013	0.01	0	42.6	38.3	54.6	134	120	0	35	31
2015	7	12	14	43	6	0.758	-0.118	4.127	0.01	0.007	0	42.1	38.3	53.8	133	120	0	35	31
2015	7	12	14	53	6	0.84	-0.089	4.127	0.01	0.007	0	42.1	37.4	55	133	119	0	35	32
2015	7	12	15	3	6	0.801	-0.121	4.124	0.01	0.007	0	42.6	37.4	58.9	133	119	0	34	32
2015	7	12	15	13	6	0.823	-0.082	4.127	0.01	0.007	0	42.6	37.8	53.3	133	119	0	34	31
2015	7	12	15	23	6	0.797	-0.092	4.127	0.01	0.007	0	42.6	37.4	53.8	133	119	0	34	32
2015	7	12	15	33	6	0.794	-0.095	4.127	0.01	0.007	0	42.1	37.8	55	133	119	0	35	31
2015	7	12	15	43	6	0.748	-0.085	4.127	0.01	0.007	0	43	37.8	54.2	134	120	0	34	32
2015	7	12	15	53	6	0.794	-0.121	4.124	0.01	0.007	0	42.6	38.3	52.9	133	120	0	34	31
2015	7	12	16	3	6	0.745	-0.092	4.124	0.01	0.007	0	42.6	37.4	53.3	133	119	0	34	32
2015	7	12	16	13	6	0.781	-0.102	4.124	0.013	0.01	0	43	37.8	54.6	134	120	0	34	32
2015	7	12	16	23	6	0.787	-0.102	4.124	0.01	0.007	0	42.6	37.8	51.6	134	120	0	35	32
2015	7	12	16	33	6	0.738	-0.098	4.124	0.013	0.01	0	43	38.3	54.2	134	120	0	34	31
2015	7	12	16	43	6	0.794	-0.092	4.124	0.01	0.007	0	43.9	39.1	52.9	136	122	0	34	31
2015	7	12	16	53	6	0.774	-0.089	4.124	0.013	0.01	0	43.4	38.7	53.8	136	121	0	35	31
2015	7	12	17	3	6	0.751	-0.072	4.124	0.01	0.007	0	43.4	38.7	52.5	136	122	0	35	32
2015	7	12	17	13	6	0.784	-0.062	4.127	0.01	0.007	0	43.9	38.7	52.5	136	122	0	34	32
2015	7	12	17	23	6	0.741	-0.095	4.124	0.01	0.007	0	43.4	38.7	52	136	122	0	35	32
2015	7	12	17	33	6	0.745	-0.089	4.124	0.01	0.007	0	43.9	39.6	54.6	136	123	0	34	31
2015	7	12	17	43	6	0.758	-0.115	4.121	0.016	0.013	0	43.9	38.3	52.9	136	121	0	34	32
2015	7	12	17	53	6	0.774	-0.098	4.124	0.013	0.01	0	43.4	38.3	54.2	136	121	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	12	18	3	6	0.751	-0.082	4.124	0.013	0.01	0	43.9	38.7	50.7	136	122	0	34	32
2015	7	12	18	13	6	0.784	-0.072	4.124	0.01	0.007	0	43.9	38.7	53.3	136	122	0	34	32
2015	7	12	18	23	6	0.768	-0.095	4.124	0.01	0.007	0	43.9	38.7	54.2	136	121	0	34	31
2015	7	12	18	33	6	0.748	-0.102	4.124	0.013	0.01	0	43.9	39.1	51.2	136	122	0	34	31
2015	7	12	18	43	6	0.761	-0.089	4.124	0.013	0.01	0	43.9	38.7	52	136	122	0	34	32
2015	7	12	18	53	6	0.768	-0.105	4.124	0.01	0.007	0	43.9	38.3	53.8	136	121	0	34	32
2015	7	12	19	3	6	0.797	-0.092	4.124	0.013	0.01	0	43.4	38.3	56.3	135	121	0	34	32
2015	7	12	19	13	6	0.774	-0.102	4.124	0.01	0.007	0	43.4	38.3	53.3	135	121	0	34	32
2015	7	12	19	23	6	0.81	-0.092	4.127	0.016	0.013	0	43.4	38.3	51.6	135	121	0	34	32
2015	7	12	19	33	6	0.768	-0.072	4.124	0.01	0.007	0	43.4	38.3	58	135	120	0	34	31
2015	7	12	19	43	6	0.784	-0.098	4.124	0.01	0.007	0	43	37.8	60.6	134	120	0	34	32
2015	7	12	19	53	6	0.755	-0.112	4.124	0.016	0.013	0	43	37.8	61.5	134	120	0	34	32
2015	7	12	20	3	6	0.797	-0.118	4.124	0.01	0.007	0	43.4	37.8	66.7	135	120	0	34	32
2015	7	12	20	13	6	0.745	-0.066	4.127	0.01	0.007	0	43.4	38.3	69.7	135	121	0	34	32
2015	7	12	20	23	6	0.774	-0.092	4.131	0.013	0.01	0	43.4	37.4	72.2	135	120	0	34	33
2015	7	12	20	33	6	0.778	-0.105	4.131	0.01	0.007	0	43	38.3	68.8	135	121	0	35	32
2015	7	12	20	43	6	0.787	-0.102	4.131	0.016	0.013	0	43	38.3	56.8	135	121	0	35	32
2015	7	12	20	53	6	0.745	-0.098	4.131	0.01	0.007	0	43.9	38.7	64.9	136	122	0	34	32
2015	7	12	21	3	6	0.761	-0.098	4.134	0.013	0.01	0	43.9	38.7	63.2	136	122	0	34	32
2015	7	12	21	13	6	0.778	-0.079	4.134	0.013	0.01	0	43.4	38.7	64.5	135	121	0	34	31
2015	7	12	21	23	6	0.781	-0.069	4.134	0.01	0.007	0	43	38.3	65.4	135	121	0	35	32
2015	7	12	21	33	6	0.761	-0.082	4.134	0.013	0.01	0	43.4	38.7	62.4	135	121	0	34	31
2015	7	12	21	43	6	0.781	-0.095	4.137	0.013	0.01	0	43	37.8	72.7	134	120	0	34	32
2015	7	12	21	53	6	0.81	-0.105	4.137	0.01	0.007	0	42.1	37.4	70.5	133	119	0	35	32
2015	7	12	22	3	6	0.791	-0.082	4.137	0.01	0.007	0	42.6	37.4	57.6	133	119	0	34	32
2015	7	12	22	13	6	0.761	-0.082	4.137	0.01	0.007	0	42.6	37.8	63.2	134	120	0	35	32
2015	7	12	22	23	6	0.794	-0.079	4.137	0.013	0.01	0	43	37.4	71	134	119	0	34	32
2015	7	12	22	33	6	0.771	-0.092	4.14	0.016	0.013	0	43	37.8	68.4	134	120	0	34	32
2015	7	12	22	43	6	0.791	-0.121	4.14	0.01	0.007	0	43	37.8	73.1	134	120	0	34	32
2015	7	12	22	53	6	0.748	-0.085	4.14	0.01	0.007	0	43.4	38.3	73.5	135	121	0	34	32
2015	7	12	23	3	6	0.755	-0.092	4.14	0.01	0.007	0	42.6	37.8	67.1	133	120	0	34	32
2015	7	12	23	13	6	0.804	-0.128	4.14	0.01	0.007	0	43	37.4	66.7	135	119	0	35	32
2015	7	12	23	23	6	0.764	-0.085	4.14	0.01	0.007	0	43.4	38.3	66.2	135	120	0	34	31
2015	7	12	23	33	6	0.758	-0.095	4.14	0.01	0.007	0	43.4	37.8	63.6	135	120	0	34	32
2015	7	12	23	43	6	0.778	-0.089	4.14	0.01	0.007	0	43	38.3	56.3	134	120	0	34	31
2015	7	12	23	53	6	0.778	-0.115	4.14	0.01	0.007	0	42.6	37.4	55	134	119	0	35	32
2015	7	13	0	3	6	0.774	-0.108	4.14	0.013	0.01	0	42.6	37.8	56.3	134	119	0	35	31
2015	7	13	0	13	6	0.738	-0.082	4.14	0.01	0.007	0	43	38.3	59.8	135	121	0	35	32
2015	7	13	0	23	6	0.807	-0.098	4.144	0.01	0.007	0	43	37.4	60.6	134	119	0	34	32
2015	7	13	0	33	6	0.771	-0.112	4.144	0.01	0.007	0	43	37.4	57.6	134	119	0	34	32
2015	7	13	0	43	6	0.774	-0.079	4.144	0.013	0.01	0	42.6	37.4	62.4	134	119	0	35	32
2015	7	13	0	53	6	0.787	-0.092	4.144	0.01	0.007	0	42.6	37.8	64.5	134	119	0	35	31
2015	7	13	1	3	6	0.745	-0.098	4.144	0.01	0.007	0	42.1	37	73.5	133	118	0	35	32
2015	7	13	1	13	6	0.774	-0.062	4.144	0.01	0.007	0	42.1	37.4	77	133	118	0	35	31
2015	7	13	1	23	6	0.758	-0.082	4.144	0.01	0.007	0	42.1	37	76.1	133	118	0	35	32
2015	7	13	1	33	6	0.758	-0.108	4.144	0.01	0.007	0	42.6	37.4	77	133	118	0	34	31
2015	7	13	1	43	6	0.856	-0.085	4.144	0.013	0.01	0	42.1	37	76.5	133	118	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	13	1	53	6	0.823	-0.072	4.144	0.01	0.007	0	42.6	37	76.1	133	118	0	34	32
2015	7	13	2	3	6	0.837	-0.095	4.144	0.01	0.007	0	42.1	36.5	76.1	132	117	0	34	32
2015	7	13	2	13	6	0.827	-0.108	4.147	0.013	0.01	0	42.1	37	75.7	133	118	0	35	32
2015	7	13	2	23	6	0.827	-0.089	4.147	0.013	0.01	0	42.6	36.5	76.5	133	117	0	34	32
2015	7	13	2	33	6	0.807	-0.079	4.144	0.01	0.007	0	42.1	36.5	76.5	132	117	0	34	32
2015	7	13	2	43	6	0.817	-0.121	4.144	0.01	0.007	0	41.7	37.4	76.5	132	118	0	35	31
2015	7	13	2	53	6	0.85	-0.079	4.147	0.01	0.007	0	42.1	37	76.1	132	117	0	34	31
2015	7	13	3	3	6	0.807	-0.102	4.147	0.013	0.01	0	42.1	36.5	76.5	132	117	0	34	32
2015	7	13	3	13	6	0.817	-0.098	4.147	0.016	0.013	0	42.1	37.4	76.1	133	119	0	35	32
2015	7	13	3	23	6	0.86	-0.075	4.147	0.013	0.01	0	42.1	37	76.1	133	118	0	35	32
2015	7	13	3	33	6	0.801	-0.072	4.147	0.013	0.01	0	43	37.4	76.1	134	119	0	34	32
2015	7	13	3	43	6	0.807	-0.079	4.147	0.01	0.007	0	42.6	37.4	75.7	133	118	0	34	31
2015	7	13	3	53	6	0.814	-0.102	4.147	0.01	0.007	0	42.6	37.4	76.1	133	118	0	34	31
2015	7	13	4	3	6	0.781	-0.118	4.147	0.013	0.01	0	42.1	37.8	76.5	133	119	0	35	31
2015	7	13	4	13	6	0.827	-0.066	4.147	0.01	0.007	0	43	37.8	76.5	134	119	0	34	31
2015	7	13	4	23	6	0.814	-0.085	4.147	0.01	0.007	0	42.6	37	76.5	133	119	0	34	33
2015	7	13	4	33	6	0.787	-0.059	4.147	0.01	0.007	0	42.6	37.4	76.5	133	118	0	34	31
2015	7	13	4	43	6	0.768	-0.062	4.147	0.01	0.007	0	43	37.4	75.7	134	119	0	34	32
2015	7	13	4	53	6	0.837	-0.079	4.147	0.01	0.007	0	43	37.4	76.1	134	119	0	34	32
2015	7	13	5	3	6	0.791	-0.079	4.147	0.01	0.007	0	43	37.4	74.8	134	119	0	34	32
2015	7	13	5	13	6	0.748	-0.066	4.147	0.01	0.007	0	42.6	38.3	75.7	134	120	0	35	31
2015	7	13	5	23	6	0.823	-0.095	4.147	0.01	0.007	0	43	38.3	75.7	134	120	0	34	31
2015	7	13	5	33	6	0.833	-0.089	4.147	0.01	0.007	0	43	37.8	75.3	134	119	0	34	31
2015	7	13	5	43	6	0.83	-0.121	4.147	0.013	0.01	0	43.4	37.8	75.3	135	120	0	34	32
2015	7	13	5	53	6	0.83	-0.075	4.147	0.01	0.007	0	43	38.3	74.8	135	120	0	35	31
2015	7	13	6	3	6	0.784	-0.102	4.147	0.01	0.007	0	43	37.8	75.3	135	120	0	35	32
2015	7	13	6	13	6	0.833	-0.089	4.147	0.01	0.007	0	42.6	37.4	74.8	134	119	0	35	32
2015	7	13	6	23	6	0.843	-0.089	4.147	0.01	0.007	0	43	37.8	75.3	134	119	0	34	31
2015	7	13	6	33	6	0.827	-0.072	4.147	0.01	0.007	0	43	37.4	75.3	134	119	0	34	32
2015	7	13	6	43	6	0.846	-0.092	4.147	0.01	0.007	0	42.6	37.4	74.8	134	119	0	35	32
2015	7	13	6	53	6	0.81	-0.098	4.147	0.01	0.007	0	42.6	37.4	74.4	134	119	0	35	32
2015	7	13	7	3	6	0.804	-0.121	4.15	0.013	0.01	0	42.1	37	74.4	133	118	0	35	32
2015	7	13	7	13	6	0.82	-0.046	4.15	0.01	0.007	0	42.1	37	74	133	118	0	35	32
2015	7	13	7	23	6	0.837	-0.089	4.15	0.013	0.01	0	42.1	37	74.4	133	118	0	35	32
2015	7	13	7	33	6	0.833	-0.046	4.15	0.013	0.01	0	42.6	37.4	74	133	118	0	34	31
2015	7	13	7	43	6	0.81	-0.105	4.15	0.013	0.01	0	42.6	37.8	74	134	120	0	35	32
2015	7	13	7	53	6	0.781	-0.105	4.15	0.01	0.007	0	42.6	37	73.5	134	119	0	35	33
2015	7	13	8	3	6	0.797	-0.059	4.15	0.01	0.007	0	43	37.4	74	134	120	0	34	33
2015	7	13	8	13	6	0.807	-0.075	4.15	0.01	0.007	0	42.1	37.4	74.4	133	119	0	35	32
2015	7	13	8	23	6	0.801	-0.062	4.15	0.013	0.01	0	42.1	37.4	74	133	119	0	35	32
2015	7	13	8	33	6	0.837	-0.105	4.15	0.01	0.007	0	42.1	37	73.5	133	118	0	35	32
2015	7	13	8	43	6	0.791	-0.079	4.15	0.01	0.007	0	42.6	37.8	73.5	134	120	0	35	32
2015	7	13	8	53	6	0.794	-0.098	4.15	0.01	0.007	0	43	37.4	73.5	134	119	0	34	32
2015	7	13	9	3	6	0.768	-0.095	4.15	0.01	0.007	0	42.6	37.4	73.1	134	119	0	35	32
2015	7	13	9	13	6	0.846	-0.085	4.154	0.01	0.007	0	42.1	37.8	73.5	133	119	0	35	31
2015	7	13	9	23	6	0.823	-0.092	4.15	0.01	0.007	0	42.1	37.4	73.1	133	119	0	35	32
2015	7	13	9	33	6	0.814	-0.095	4.154	0.01	0.007	0	42.1	37.4	73.5	133	119	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	13	9	43	6	0.823	-0.092	4.154	0.01	0.007	0	42.1	37	72.7	133	119	0	35	33
2015	7	13	9	53	6	0.823	-0.085	4.154	0.01	0.007	0	42.6	37	73.5	133	119	0	34	33
2015	7	13	10	3	6	0.797	-0.095	4.154	0.013	0.01	0	42.1	37.4	73.1	133	119	0	35	32
2015	7	13	10	13	6	0.801	-0.092	4.154	0.013	0.01	0	42.1	37.4	73.5	133	119	0	35	32
2015	7	13	10	23	6	0.784	-0.079	4.154	0.016	0.013	0	42.6	37.8	72.7	133	120	0	34	32
2015	7	13	10	33	6	0.804	-0.098	4.154	0.01	0.007	0	42.6	37.4	73.5	134	119	0	35	32
2015	7	13	10	43	6	0.843	-0.105	4.154	0.01	0.007	0	43	37.8	73.1	134	120	0	34	32
2015	7	13	10	53	6	0.801	-0.079	4.154	0.01	0.007	0	42.6	37.8	73.1	134	120	0	35	32
2015	7	13	11	3	6	0.846	-0.095	4.154	0.01	0.007	0	42.6	37.8	73.1	134	120	0	35	32
2015	7	13	11	13	6	0.843	-0.079	4.154	0.013	0.01	0	42.6	37.4	74	133	119	0	34	32
2015	7	13	11	23	6	0.837	-0.121	4.154	0.013	0.01	0	42.6	37.8	73.1	133	119	0	34	31
2015	7	13	11	33	6	0.784	-0.089	4.154	0.013	0.01	0	42.1	37	73.1	133	119	0	35	33
2015	7	13	11	43	6	0.856	-0.108	4.154	0.013	0.01	0	42.1	37.8	74.4	133	119	0	35	31
2015	7	13	11	53	6	0.774	-0.079	4.154	0.01	0.007	0	41.7	37	72.7	132	118	0	35	32
2015	7	13	12	3	6	0.814	-0.079	4.154	0.01	0.007	0	42.1	37.4	73.5	133	119	0	35	32
2015	7	13	12	13	6	0.774	-0.079	4.154	0.01	0.007	0	41.7	37	67.5	132	118	0	35	32
2015	7	13	12	23	6	0.794	-0.121	4.154	0.013	0.01	0	42.1	37	60.6	132	118	0	34	32
2015	7	13	12	33	6	0.791	-0.092	4.154	0.013	0.01	0	42.1	37.4	67.9	133	119	0	35	32
2015	7	13	12	43	6	0.801	-0.098	4.154	0.01	0.007	0	42.6	37.4	58.9	133	119	0	34	32
2015	7	13	12	53	6	0.761	-0.082	4.154	0.016	0.013	0	42.1	37.4	69.7	132	118	0	34	31
2015	7	13	13	3	6	0.797	-0.118	4.154	0.01	0.007	0	42.1	37.4	58	132	118	0	34	31
2015	7	13	13	13	6	0.784	-0.066	4.154	0.013	0.01	0	42.1	37	57.2	133	119	0	35	33
2015	7	13	13	23	6	0.764	-0.125	4.154	0.01	0.007	0	42.1	37.4	58	132	118	0	34	31
2015	7	13	13	33	6	0.794	-0.059	4.154	0.01	0.007	0	42.6	37.8	61.5	133	119	0	34	31
2015	7	13	13	43	6	0.827	-0.095	4.154	0.01	0.007	0	42.6	37.4	57.6	133	119	0	34	32
2015	7	13	13	53	6	0.781	-0.062	4.15	0.01	0.007	0	42.1	37.4	73.5	133	119	0	35	32
2015	7	13	14	3	6	0.81	-0.089	4.154	0.01	0.007	0	41.7	37	72.7	132	118	0	35	32
2015	7	13	14	13	6	0.817	-0.105	4.154	0.01	0.007	0	42.1	37.4	65.8	133	119	0	35	32
2015	7	13	14	23	6	0.807	-0.115	4.154	0.01	0.007	0	42.1	37	57.2	133	118	0	35	32
2015	7	13	14	33	6	0.774	-0.121	4.154	0.01	0.007	0	42.6	37.4	67.9	133	119	0	34	32
2015	7	13	14	43	6	0.771	-0.108	4.15	0.01	0.007	0	42.6	37.8	64.9	133	119	0	34	31
2015	7	13	14	53	6	0.791	-0.089	4.154	0.01	0.007	0	42.6	37.4	60.6	133	119	0	34	32
2015	7	13	15	3	6	0.807	-0.098	4.15	0.01	0.007	0	42.1	37.8	67.1	133	119	0	35	31
2015	7	13	15	13	6	0.814	-0.095	4.15	0.01	0.007	0	42.6	37.4	62.8	133	119	0	34	32
2015	7	13	15	23	6	0.761	-0.082	4.154	0.01	0.007	0	42.6	37.4	58	133	119	0	34	32
2015	7	13	15	33	6	0.787	-0.095	4.15	0.01	0.007	0	43	37.8	55.5	134	120	0	34	32
2015	7	13	15	43	6	0.784	-0.089	4.15	0.01	0.007	0	43.4	38.3	57.2	135	120	0	34	31
2015	7	13	15	53	6	0.797	-0.066	4.15	0.01	0.007	0	42.6	37.8	55	134	120	0	35	32
2015	7	13	16	3	6	0.801	-0.095	4.15	0.01	0.007	0	43	37.8	55.5	134	120	0	34	32
2015	7	13	16	13	6	0.791	-0.112	4.15	0.01	0.007	0	43	37.8	56.3	134	119	0	34	31
2015	7	13	16	23	6	0.748	-0.085	4.15	0.013	0.01	0	42.6	37.8	56.3	133	119	0	34	31
2015	7	13	16	33	6	0.784	-0.121	4.15	0.013	0.01	0	42.6	38.3	52	134	120	0	35	31
2015	7	13	16	43	6	0.787	-0.092	4.15	0.01	0.007	0	42.6	37.4	56.3	133	119	0	34	32
2015	7	13	16	53	6	0.801	-0.115	4.15	0.013	0.01	0	42.6	37.8	54.2	133	119	0	34	31
2015	7	13	17	3	6	0.738	-0.102	4.15	0.01	0.007	0	42.1	37.4	56.3	133	119	0	35	32
2015	7	13	17	13	6	0.807	-0.056	4.15	0.01	0.007	0	43	37.4	51.6	134	119	0	34	32
2015	7	13	17	23	6	0.83	-0.089	4.15	0.01	0.007	0	42.6	37	57.6	133	118	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	13	17	33	6	0.741	-0.072	4.15	0.01	0.007	0	42.1	37.8	56.3	132	119	0	34	31
2015	7	13	17	43	6	0.81	-0.118	4.15	0.01	0.007	0	42.6	37.8	58.9	133	119	0	34	31
2015	7	13	17	53	6	0.745	-0.069	4.15	0.016	0.013	0	42.6	37.4	64.5	133	119	0	34	32
2015	7	13	18	3	6	0.764	-0.105	4.15	0.01	0.007	0	42.1	37	55.9	132	118	0	34	32
2015	7	13	18	13	6	0.82	-0.108	4.15	0.01	0.007	0	42.6	37	62.8	133	118	0	34	32
2015	7	13	18	23	6	0.768	-0.072	4.15	0.01	0.007	0	42.6	37.4	58.5	133	118	0	34	31
2015	7	13	18	33	6	0.797	-0.085	4.15	0.01	0.007	0	42.1	37	75.3	132	117	0	34	31
2015	7	13	18	43	6	0.781	-0.085	4.15	0.016	0.013	0	42.1	37	72.2	132	117	0	34	31
2015	7	13	18	53	6	0.794	-0.069	4.15	0.01	0.007	0	42.1	36.5	76.1	132	117	0	34	32
2015	7	13	19	3	6	0.817	-0.066	4.15	0.01	0.007	0	42.1	36.5	77	132	117	0	34	32
2015	7	13	19	13	6	0.781	-0.082	4.15	0.01	0.007	0	42.1	36.5	76.1	132	117	0	34	32
2015	7	13	19	23	6	0.823	-0.089	4.15	0.01	0.007	0	42.1	37	76.1	132	117	0	34	31
2015	7	13	19	33	6	0.781	-0.062	4.15	0.01	0.007	0	42.1	37	76.1	132	118	0	34	32
2015	7	13	19	43	6	0.794	-0.102	4.15	0.01	0.007	0	41.7	37	76.5	132	117	0	35	31
2015	7	13	19	53	6	0.807	-0.098	4.15	0.01	0.007	0	41.7	36.5	76.5	132	117	0	35	32
2015	7	13	20	3	6	0.823	-0.079	4.154	0.01	0.007	0	42.6	36.5	76.5	133	117	0	34	32
2015	7	13	20	13	6	0.84	-0.089	4.154	0.01	0.007	0	42.6	36.5	75.7	133	117	0	34	32
2015	7	13	20	23	6	0.817	-0.049	4.154	0.01	0.007	0	42.1	36.5	76.1	132	117	0	34	32
2015	7	13	20	33	6	0.807	-0.066	4.154	0.01	0.007	0	43	37.4	71	134	119	0	34	32
2015	7	13	20	43	6	0.781	-0.085	4.154	0.013	0.01	0	43.4	38.3	74.8	135	120	0	34	31
2015	7	13	20	53	6	0.82	-0.085	4.154	0.013	0.01	0	43.4	38.3	74.4	135	121	0	34	32
2015	7	13	21	3	6	0.817	-0.046	4.154	0.01	0.007	0	43.4	37.8	74.8	135	120	0	34	32
2015	7	13	21	13	6	0.83	-0.092	4.154	0.016	0.013	0	43	38.3	74.8	134	120	0	34	31
2015	7	13	21	23	6	0.843	-0.095	4.154	0.013	0.01	0	43	38.3	75.7	135	120	0	35	31
2015	7	13	21	33	6	0.83	-0.089	4.154	0.01	0.007	0	43	38.3	75.7	134	120	0	34	31
2015	7	13	21	43	6	0.817	-0.072	4.154	0.01	0.007	0	43	37.8	76.1	134	119	0	34	31
2015	7	13	21	53	6	0.761	-0.082	4.154	0.01	0.007	0	42.6	37.4	75.7	134	119	0	35	32
2015	7	13	22	3	6	0.781	-0.075	4.154	0.01	0.007	0	42.6	37.8	74	134	119	0	35	31
2015	7	13	22	13	6	0.801	-0.089	4.157	0.01	0.007	0	43	37.4	74.8	133	119	0	33	32
2015	7	13	22	23	6	0.768	-0.105	4.157	0.013	0.01	0	43	37.8	73.5	134	120	0	34	32
2015	7	13	22	33	6	0.801	-0.079	4.157	0.013	0.01	0	42.6	37.4	74.4	133	118	0	34	31
2015	7	13	22	43	6	0.764	-0.115	4.157	0.01	0.007	0	42.1	37.4	74	133	118	0	35	31
2015	7	13	22	53	6	0.81	-0.112	4.157	0.01	0.007	0	43	37	73.5	133	118	0	33	32
2015	7	13	23	3	6	0.787	-0.085	4.157	0.013	0.01	0	42.6	37.4	71.4	133	119	0	34	32
2015	7	13	23	13	6	0.778	-0.098	4.157	0.01	0.007	0	42.1	37.4	65.8	133	119	0	35	32
2015	7	13	23	23	6	0.774	-0.112	4.157	0.01	0.007	0	43	37	66.2	134	118	0	34	32
2015	7	13	23	33	6	0.764	-0.092	4.157	0.01	0.007	0	42.6	37	74	133	118	0	34	32
2015	7	13	23	43	6	0.771	-0.082	4.157	0.013	0.01	0	42.1	36.5	70.5	133	118	0	35	33
2015	7	13	23	53	6	0.774	-0.089	4.157	0.01	0.007	0	42.6	37.4	69.2	133	119	0	34	32
2015	7	14	0	3	6	0.817	-0.105	4.16	0.01	0.007	0	43	37.4	73.1	134	119	0	34	32
2015	7	14	0	13	6	0.843	-0.085	4.16	0.01	0.007	0	43	37.4	74	134	119	0	34	32
2015	7	14	0	23	6	0.791	-0.072	4.16	0.01	0.007	0	43.4	37.8	74	134	120	0	33	32
2015	7	14	0	33	6	0.751	-0.062	4.16	0.013	0.01	0	42.6	37	73.5	133	118	0	34	32
2015	7	14	0	43	6	0.804	-0.085	4.16	0.01	0.007	0	42.1	36.5	71.8	132	117	0	34	32
2015	7	14	0	53	6	0.745	-0.085	4.16	0.013	0.01	0	42.1	36.5	73.5	132	117	0	34	32
2015	7	14	1	3	6	0.791	-0.089	4.16	0.01	0.007	0	42.1	36.1	72.7	132	116	0	34	32
2015	7	14	1	13	6	0.814	-0.079	4.16	0.013	0.01	0	41.7	36.5	74	132	117	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	14	1	23	6	0.876	-0.108	4.163	0.013	0.01	0	41.3	36.1	72.7	131	116	0	35	32
2015	7	14	1	33	6	0.781	-0.049	4.163	0.01	0.007	0	42.1	37	72.2	133	118	0	35	32
2015	7	14	1	43	6	0.817	-0.066	4.167	0.01	0.007	0	42.6	37	71.8	133	118	0	34	32
2015	7	14	1	53	6	0.81	-0.085	4.17	0.01	0.007	0	42.1	36.5	73.1	132	117	0	34	32
2015	7	14	2	3	6	0.837	-0.092	4.173	0.01	0.007	0	41.7	36.5	72.7	132	117	0	35	32
2015	7	14	2	13	6	0.843	-0.135	4.173	0.01	0.007	0	42.1	37.4	73.1	132	118	0	34	31
2015	7	14	2	23	6	0.85	-0.072	4.177	0.01	0.007	0	42.6	37	73.5	133	118	0	34	32
2015	7	14	2	33	6	0.81	-0.092	4.177	0.013	0.01	0	42.1	37	74	133	118	0	35	32
2015	7	14	2	43	6	0.81	-0.098	4.177	0.01	0.007	0	42.1	36.5	73.1	132	117	0	34	32
2015	7	14	2	53	6	0.843	-0.092	4.177	0.01	0.007	0	42.1	36.5	74.4	132	117	0	34	32
2015	7	14	3	3	6	0.814	-0.046	4.177	0.01	0.007	0	41.7	37.4	74	132	118	0	35	31
2015	7	14	3	13	6	0.827	-0.108	4.177	0.01	0.007	0	41.7	37	74.4	132	117	0	35	31
2015	7	14	3	23	6	0.869	-0.079	4.18	0.01	0.007	0	42.1	37	74.8	132	118	0	34	32
2015	7	14	3	33	6	0.784	-0.112	4.18	0.01	0.007	0	42.1	36.5	74.8	132	118	0	34	33
2015	7	14	3	43	6	0.846	-0.085	4.18	0.01	0.007	0	42.1	37	75.3	133	118	0	35	32
2015	7	14	3	53	6	0.814	-0.092	4.18	0.01	0.007	0	42.6	37.4	74.8	133	118	0	34	31
2015	7	14	4	3	6	0.869	-0.072	4.18	0.013	0.01	0	42.6	37	75.7	133	118	0	34	32
2015	7	14	4	13	6	0.846	-0.069	4.18	0.01	0.007	0	42.6	37.4	76.1	133	118	0	34	31
2015	7	14	4	23	6	0.83	-0.092	4.18	0.016	0.013	0	42.1	37.4	75.7	133	119	0	35	32
2015	7	14	4	33	6	0.833	-0.098	4.18	0.01	0.007	0	43	37.4	76.1	134	119	0	34	32
2015	7	14	4	43	6	0.774	-0.121	4.18	0.01	0.007	0	43	37.8	75.7	135	119	0	35	31
2015	7	14	4	53	6	0.81	-0.095	4.18	0.01	0.007	0	43	37.4	75.7	134	119	0	34	32
2015	7	14	5	3	6	0.823	-0.108	4.18	0.016	0.013	0	42.6	37.4	76.1	133	119	0	34	32
2015	7	14	5	13	6	0.846	-0.108	4.183	0.01	0.007	0	42.6	37	77	133	118	0	34	32
2015	7	14	5	23	6	0.801	-0.105	4.183	0.013	0.01	0	42.1	37.4	76.5	133	118	0	35	31
2015	7	14	5	33	6	0.804	-0.095	4.183	0.01	0.007	0	42.6	37.4	76.5	133	119	0	34	32
2015	7	14	5	43	6	0.823	-0.085	4.183	0.01	0.007	0	43.4	37.8	76.5	134	119	0	33	31
2015	7	14	5	53	6	0.863	-0.102	4.183	0.01	0.007	0	42.1	37.4	77	133	119	0	35	32
2015	7	14	6	3	6	0.833	-0.095	4.183	0.01	0.007	0	43	38.3	76.5	134	120	0	34	31
2015	7	14	6	13	6	0.82	-0.098	4.183	0.013	0.01	0	42.1	37.8	76.1	133	119	0	35	31
2015	7	14	6	23	6	0.817	-0.115	4.183	0.01	0.007	0	42.6	37.4	76.5	134	119	0	35	32
2015	7	14	6	33	6	0.807	-0.125	4.183	0.01	0.007	0	42.1	37.4	75.7	133	119	0	35	32
2015	7	14	6	43	6	0.81	-0.082	4.183	0.01	0.007	0	42.6	37	76.5	133	119	0	34	33
2015	7	14	6	53	6	0.837	-0.098	4.183	0.01	0.007	0	42.6	37	76.1	133	118	0	34	32
2015	7	14	7	3	6	0.846	-0.102	4.183	0.013	0.01	0	42.6	37.4	75.7	133	118	0	34	31
2015	7	14	7	13	6	0.837	-0.102	4.183	0.01	0.007	0	42.1	37	75.7	132	118	0	34	32
2015	7	14	7	23	6	0.82	-0.102	4.183	0.01	0.007	0	42.1	37	76.5	132	117	0	34	31
2015	7	14	7	33	6	0.846	-0.125	4.183	0.01	0.007	0	42.1	36.5	76.5	132	117	0	34	32
2015	7	14	7	43	6	0.797	-0.069	4.183	0.013	0.01	0	42.1	37	77	132	118	0	34	32
2015	7	14	7	53	6	0.81	-0.112	4.183	0.01	0.007	0	42.1	37.4	76.5	132	118	0	34	31
2015	7	14	8	3	6	0.86	-0.105	4.183	0.01	0.007	0	42.1	36.5	76.1	132	117	0	34	32
2015	7	14	8	13	6	0.817	-0.105	4.183	0.016	0.016	0	42.1	37	76.5	132	118	0	34	32
2015	7	14	8	23	6	0.823	-0.118	4.183	0.01	0.007	0	41.7	36.5	76.1	132	117	0	35	32
2015	7	14	8	33	6	0.846	-0.092	4.183	0.01	0.007	0	41.7	37	75.7	131	117	0	34	31
2015	7	14	8	43	6	0.83	-0.108	4.183	0.01	0.007	0	41.3	36.5	77	131	116	0	35	31
2015	7	14	8	53	6	0.794	-0.112	4.183	0.01	0.007	0	42.1	36.5	76.5	132	117	0	34	32
2015	7	14	9	3	6	0.774	-0.135	4.183	0.01	0.007	0	42.1	36.5	76.5	132	117	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	14	9	13	6	0.82	-0.089	4.183	0.01	0.007	0	41.7	36.5	76.5	131	117	0	34	32
2015	7	14	9	23	6	0.787	-0.095	4.183	0.01	0.007	0	41.7	36.5	76.1	131	117	0	34	32
2015	7	14	9	33	6	0.86	-0.105	4.183	0.01	0.007	0	42.1	37	75.7	132	117	0	34	31
2015	7	14	9	43	6	0.82	-0.108	4.183	0.01	0.007	0	41.7	36.5	75.3	131	117	0	34	32
2015	7	14	9	53	6	0.774	-0.069	4.183	0.01	0.007	0	41.7	37	75.7	132	118	0	35	32
2015	7	14	10	3	6	0.823	-0.066	4.186	0.01	0.007	0	42.1	37	74.4	132	118	0	34	32
2015	7	14	10	13	6	0.82	-0.112	4.186	0.01	0.007	0	41.7	36.5	75.3	132	118	0	35	33
2015	7	14	10	23	6	0.807	-0.141	4.183	0.01	0.007	0	41.7	36.5	69.2	132	117	0	35	32
2015	7	14	10	33	6	0.837	-0.105	4.186	0.013	0.01	0	42.1	37.4	72.7	133	119	0	35	32
2015	7	14	10	43	6	0.814	-0.128	4.183	0.01	0.007	0	42.1	36.5	63.6	132	118	0	34	33
2015	7	14	10	53	6	0.781	-0.095	4.186	0.01	0.007	0	42.1	37	72.2	132	118	0	34	32
2015	7	14	11	3	6	0.81	-0.115	4.183	0.01	0.007	0	41.7	37	62.4	132	118	0	35	32
2015	7	14	11	13	6	0.787	-0.098	4.183	0.01	0.007	0	42.1	37	71.8	132	118	0	34	32
2015	7	14	11	23	6	0.81	-0.105	4.183	0.01	0.007	0	41.7	36.5	69.2	132	117	0	35	32
2015	7	14	11	33	6	0.83	-0.125	4.186	0.016	0.013	0	41.7	36.5	67.1	132	117	0	35	32
2015	7	14	11	43	6	0.807	-0.115	4.183	0.01	0.007	0	42.1	37.8	64.5	133	119	0	35	31
2015	7	14	11	53	6	0.814	-0.075	4.183	0.01	0.007	0	41.7	37.4	70.1	132	119	0	35	32
2015	7	14	12	3	6	0.833	-0.082	4.183	0.01	0.007	0	42.6	37.4	64.1	133	119	0	34	32
2015	7	14	12	13	6	0.794	-0.112	4.183	0.01	0.007	0	42.6	38.3	60.2	133	120	0	34	31
2015	7	14	12	23	6	0.797	-0.112	4.183	0.01	0.007	0	42.1	37.8	61.9	133	119	0	35	31
2015	7	14	12	33	6	0.814	-0.092	4.183	0.01	0.007	0	42.1	37.4	61.1	133	119	0	35	32
2015	7	14	12	43	6	0.771	-0.075	4.183	0.01	0.007	0	42.1	37.4	62.8	133	119	0	35	32
2015	7	14	12	53	6	0.794	-0.095	4.183	0.01	0.007	0	42.1	37.4	58	132	118	0	34	31
2015	7	14	13	3	6	0.761	-0.072	4.183	0.01	0.007	0	42.1	37.8	57.2	132	119	0	34	31
2015	7	14	13	13	6	0.784	-0.105	4.183	0.01	0.007	0	42.1	37.4	53.8	132	119	0	34	32
2015	7	14	13	23	6	0.814	-0.082	4.183	0.01	0.007	0	42.6	37.8	60.6	133	119	0	34	31
2015	7	14	13	33	6	0.797	-0.118	4.18	0.01	0.007	0	42.6	37.4	56.3	133	119	0	34	32
2015	7	14	13	43	6	0.778	-0.075	4.18	0.01	0.007	0	42.6	37.8	57.2	133	119	0	34	31
2015	7	14	13	53	6	0.768	-0.095	4.183	0.01	0.007	0	42.6	37.4	55.9	133	119	0	34	32
2015	7	14	14	3	6	0.814	-0.062	4.18	0.01	0.007	0	42.6	37.8	56.3	133	119	0	34	31
2015	7	14	14	13	6	0.81	-0.102	4.18	0.01	0.007	0	42.1	37.4	65.8	132	118	0	34	31
2015	7	14	14	23	6	0.797	-0.089	4.177	0.016	0.013	0	41.7	37.4	55.9	132	118	0	35	31
2015	7	14	14	33	6	0.784	-0.075	4.177	0.013	0.01	0	41.3	37	52.9	131	117	0	35	31
2015	7	14	14	43	6	0.814	-0.066	4.177	0.013	0.01	0	41.7	37	54.6	132	118	0	35	32
2015	7	14	14	53	6	0.791	-0.098	4.173	0.01	0.007	0	41.7	37	55.5	131	117	0	34	31
2015	7	14	15	3	6	0.801	-0.066	4.173	0.01	0.007	0	41.7	37	54.2	131	118	0	34	32
2015	7	14	15	13	6	0.794	-0.092	4.173	0.01	0.007	0	42.1	37	53.3	132	118	0	34	32
2015	7	14	15	23	6	0.741	-0.089	4.173	0.01	0.007	0	42.1	37	53.3	133	118	0	35	32
2015	7	14	15	33	6	0.774	-0.079	4.17	0.013	0.01	0	41.7	37	52.5	131	117	0	34	31
2015	7	14	15	43	6	0.771	-0.082	4.17	0.01	0.007	0	42.1	37.4	55.5	132	118	0	34	31
2015	7	14	15	53	6	0.748	-0.082	4.17	0.01	0.007	0	41.3	36.5	54.2	131	117	0	35	32
2015	7	14	16	3	6	0.817	-0.095	4.167	0.01	0.007	0	42.1	37.4	56.8	132	118	0	34	31
2015	7	14	16	13	6	0.797	-0.089	4.167	0.01	0.007	0	42.1	36.5	52.9	132	117	0	34	32
2015	7	14	16	23	6	0.794	-0.059	4.17	0.01	0.007	0	41.7	37.4	52.5	132	118	0	35	31
2015	7	14	16	33	6	0.801	-0.062	4.167	0.01	0.007	0	41.7	37.4	55.9	132	118	0	35	31
2015	7	14	16	43	6	0.784	-0.085	4.167	0.01	0.007	0	42.1	37.4	55.9	132	118	0	34	31
2015	7	14	16	53	6	0.817	-0.092	4.163	0.01	0.007	0	42.1	37	55	132	118	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	14	17	3	6	0.814	-0.098	4.163	0.01	0.007	0	42.1	37.4	55.5	132	118	0	34	31
2015	7	14	17	13	6	0.801	-0.095	4.163	0.013	0.01	0	42.1	37	56.3	132	118	0	34	32
2015	7	14	17	23	6	0.797	-0.095	4.163	0.01	0.007	0	42.1	37	59.8	132	118	0	34	32
2015	7	14	17	33	6	0.794	-0.108	4.167	0.01	0.007	0	42.1	37.4	52.9	132	118	0	34	31
2015	7	14	17	43	6	0.781	-0.128	4.163	0.01	0.007	0	42.1	37.4	53.8	133	118	0	35	31
2015	7	14	17	53	6	0.801	-0.095	4.163	0.016	0.013	0	42.1	37.4	53.8	133	119	0	35	32
2015	7	14	18	3	6	0.768	-0.092	4.16	0.013	0.01	0	42.1	37.4	56.3	132	118	0	34	31
2015	7	14	18	13	6	0.784	-0.108	4.16	0.013	0.01	0	42.6	37	58.5	133	118	0	34	32
2015	7	14	18	23	6	0.768	-0.112	4.16	0.013	0.01	0	41.7	37.4	60.2	132	118	0	35	31
2015	7	14	18	33	6	0.827	-0.112	4.163	0.01	0.007	0	42.1	36.5	71	132	117	0	34	32
2015	7	14	18	43	6	0.751	-0.092	4.163	0.01	0.007	0	41.7	36.5	55.9	131	116	0	34	31
2015	7	14	18	53	6	0.768	-0.079	4.163	0.01	0.007	0	42.1	36.5	55.9	132	117	0	34	32
2015	7	14	19	3	6	0.748	-0.082	4.16	0.01	0.007	0	42.1	36.5	55	132	117	0	34	32
2015	7	14	19	13	6	0.774	-0.062	4.16	0.01	0.007	0	41.3	36.5	62.8	131	117	0	35	32
2015	7	14	19	23	6	0.741	-0.098	4.16	0.013	0.01	0	42.1	36.5	56.8	132	117	0	34	32
2015	7	14	19	33	6	0.784	-0.098	4.163	0.01	0.007	0	42.1	37.4	65.8	132	118	0	34	31
2015	7	14	19	43	6	0.794	-0.108	4.163	0.01	0.007	0	42.1	37	57.2	132	117	0	34	31
2015	7	14	19	53	6	0.764	-0.121	4.163	0.01	0.007	0	42.1	36.5	58.9	132	117	0	34	32
2015	7	14	20	3	6	0.804	-0.052	4.163	0.01	0.007	0	42.1	37	60.2	132	118	0	34	32
2015	7	14	20	13	6	0.758	-0.079	4.163	0.01	0.007	0	42.6	36.5	67.9	132	117	0	33	32
2015	7	14	20	23	6	0.771	-0.102	4.163	0.016	0.013	0	41.3	35.7	67.9	131	116	0	35	33
2015	7	14	20	33	6	0.784	-0.069	4.167	0.013	0.01	0	42.1	37	56.3	132	117	0	34	31
2015	7	14	20	43	6	0.768	-0.121	4.167	0.01	0.007	0	42.6	37	55.9	133	118	0	34	32
2015	7	14	20	53	6	0.791	-0.082	4.167	0.01	0.007	0	42.6	37	60.2	133	118	0	34	32
2015	7	14	21	3	6	0.784	-0.085	4.17	0.01	0.007	0	42.1	37.4	51.2	132	118	0	34	31
2015	7	14	21	13	6	0.755	-0.092	4.17	0.01	0.007	0	42.6	37.4	55.9	133	118	0	34	31
2015	7	14	21	23	6	0.738	-0.108	4.17	0.01	0.007	0	42.6	37.4	56.3	133	118	0	34	31
2015	7	14	21	33	6	0.804	-0.079	4.177	0.01	0.007	0	42.1	36.5	64.9	132	118	0	34	33
2015	7	14	21	43	6	0.758	-0.089	4.18	0.013	0.01	0	42.6	37	62.4	132	117	0	33	31
2015	7	14	21	53	6	0.787	-0.075	4.183	0.013	0.01	0	41.7	36.5	66.2	131	116	0	34	31
2015	7	14	22	3	6	0.833	-0.095	4.18	0.016	0.013	0	41.7	36.5	57.2	131	116	0	34	31
2015	7	14	22	13	6	0.768	-0.089	4.183	0.01	0.007	0	40.9	36.5	56.3	130	116	0	35	31
2015	7	14	22	23	6	0.781	-0.089	4.186	0.013	0.01	0	41.7	36.1	63.6	131	116	0	34	32
2015	7	14	22	33	6	0.787	-0.098	4.186	0.01	0.007	0	42.1	37	61.1	132	117	0	34	31
2015	7	14	22	43	6	0.83	-0.112	4.186	0.01	0.007	0	41.3	36.5	55	131	117	0	35	32
2015	7	14	22	53	6	0.761	-0.082	4.19	0.013	0.01	0	41.7	36.5	58.5	131	116	0	34	31
2015	7	14	23	3	6	0.781	-0.112	4.193	0.016	0.013	0	41.3	36.5	75.7	130	116	0	34	31
2015	7	14	23	13	6	0.784	-0.075	4.193	0.01	0.007	0	41.3	36.1	60.2	130	116	0	34	32
2015	7	14	23	23	6	0.84	-0.079	4.193	0.01	0.007	0	41.3	35.7	68.8	129	115	0	33	32
2015	7	14	23	33	6	0.814	-0.105	4.193	0.01	0.007	0	41.7	36.1	73.5	131	116	0	34	32
2015	7	14	23	43	6	0.833	-0.112	4.193	0.01	0.007	0	41.3	36.5	72.2	130	116	0	34	31
2015	7	14	23	53	6	0.873	-0.112	4.196	0.01	0.007	0	41.3	36.1	75.7	130	115	0	34	31
2015	7	15	0	3	6	0.804	-0.095	4.196	0.01	0.007	0	41.3	35.7	75.3	130	115	0	34	32
2015	7	15	0	13	6	0.837	-0.112	4.199	0.01	0.007	0	40.9	35.7	73.1	129	114	0	34	31
2015	7	15	0	23	6	0.758	-0.112	4.199	0.01	0.007	0	40.9	36.1	72.7	129	115	0	34	31
2015	7	15	0	33	6	0.768	-0.131	4.203	0.01	0.007	0	41.3	36.1	72.7	130	116	0	34	32
2015	7	15	0	43	6	0.801	-0.098	4.203	0.01	0.007	0	41.3	36.1	72.2	130	116	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	15	0	53	6	0.814	-0.095	4.206	0.01	0.007	0	41.7	36.5	72.2	131	117	0	34	32
2015	7	15	1	3	6	0.817	-0.092	4.216	0.01	0.007	0	41.7	37	72.7	131	117	0	34	31
2015	7	15	1	13	6	0.84	-0.082	4.219	0.01	0.007	0	41.7	37	73.1	131	117	0	34	31
2015	7	15	1	23	6	0.827	-0.092	4.222	0.01	0.007	0	41.7	36.5	74.4	131	117	0	34	32
2015	7	15	1	33	6	0.863	-0.095	4.222	0.016	0.013	0	41.3	36.5	75.7	130	117	0	34	32
2015	7	15	1	43	6	0.83	-0.085	4.226	0.01	0.007	0	41.7	36.5	76.1	131	117	0	34	32
2015	7	15	1	53	6	0.833	-0.079	4.226	0.013	0.01	0	41.3	36.5	76.5	130	117	0	34	32
2015	7	15	2	3	6	0.797	-0.095	4.229	0.01	0.007	0	41.3	36.5	77.4	130	116	0	34	31
2015	7	15	2	13	6	0.84	-0.079	4.229	0.01	0.007	0	41.3	36.1	77.4	130	116	0	34	32
2015	7	15	2	23	6	0.873	-0.072	4.229	0.01	0.007	0	41.7	36.5	76.5	131	117	0	34	32
2015	7	15	2	33	6	0.86	-0.092	4.232	0.013	0.01	0	41.7	37	76.5	131	117	0	34	31
2015	7	15	2	43	6	0.879	-0.105	4.232	0.01	0.007	0	41.7	37	76.1	131	117	0	34	31
2015	7	15	2	53	6	0.81	-0.144	4.232	0.01	0.007	0	42.1	37	76.1	132	118	0	34	32
2015	7	15	3	3	6	0.81	-0.075	4.236	0.01	0.007	0	41.7	37	74.8	132	118	0	35	32
2015	7	15	3	13	6	0.801	-0.105	4.239	0.01	0.007	0	41.7	36.5	74.8	131	117	0	34	32
2015	7	15	3	23	6	0.86	-0.102	4.239	0.01	0.007	0	41.7	37	74.8	131	117	0	34	31
2015	7	15	3	33	6	0.781	-0.075	4.239	0.01	0.007	0	42.1	37.4	73.5	132	118	0	34	31
2015	7	15	3	43	6	0.853	-0.095	4.242	0.013	0.01	0	42.1	37	73.5	132	118	0	34	32
2015	7	15	3	53	6	0.827	-0.105	4.252	0.01	0.007	0	42.1	37	73.5	132	118	0	34	32
2015	7	15	4	3	6	0.85	-0.095	4.255	0.01	0.007	0	42.1	37.4	73.5	132	118	0	34	31
2015	7	15	4	13	6	0.873	-0.089	4.259	0.013	0.01	0	41.7	37.4	74.4	132	118	0	35	31
2015	7	15	4	23	6	0.866	-0.141	4.259	0.01	0.007	0	42.1	37	75.3	132	118	0	34	32
2015	7	15	4	33	6	0.86	-0.095	4.262	0.01	0.007	0	42.1	37	75.7	132	118	0	34	32
2015	7	15	4	43	6	0.86	-0.095	4.262	0.01	0.007	0	42.6	37.4	76.5	133	119	0	34	32
2015	7	15	4	53	6	0.856	-0.089	4.265	0.013	0.01	0	42.6	37.8	76.1	133	119	0	34	31
2015	7	15	5	3	6	0.758	-0.098	4.265	0.01	0.007	0	42.6	37.4	76.5	133	119	0	34	32
2015	7	15	5	13	6	0.856	-0.095	4.265	0.01	0.007	0	43	38.3	76.5	134	120	0	34	31
2015	7	15	5	23	6	0.82	-0.052	4.268	0.01	0.007	0	43	37.8	76.5	134	120	0	34	32
2015	7	15	5	33	6	0.879	-0.102	4.268	0.01	0.007	0	43	38.3	76.5	134	120	0	34	31
2015	7	15	5	43	6	0.833	-0.115	4.268	0.01	0.007	0	43	37.8	76.1	134	120	0	34	32
2015	7	15	5	53	6	0.869	-0.092	4.268	0.013	0.01	0	42.1	38.3	75.7	133	120	0	35	31
2015	7	15	6	3	6	0.817	-0.072	4.272	0.01	0.007	0	43	37.4	75.3	134	119	0	34	32
2015	7	15	6	13	6	0.889	-0.108	4.272	0.013	0.01	0	43	37.8	74.4	134	120	0	34	32
2015	7	15	6	23	6	0.85	-0.098	4.272	0.01	0.007	0	42.6	37.4	74	133	119	0	34	32
2015	7	15	6	33	6	0.843	-0.072	4.275	0.013	0.01	0	43	37.8	73.5	134	120	0	34	32
2015	7	15	6	43	6	0.86	-0.089	4.275	0.013	0.01	0	42.6	38.3	72.7	133	120	0	34	31
2015	7	15	6	53	6	0.856	-0.095	4.285	0.01	0.007	0	43	37.4	72.7	134	119	0	34	32
2015	7	15	7	3	6	0.869	-0.085	4.288	0.01	0.007	0	42.6	37.8	73.5	133	119	0	34	31
2015	7	15	7	13	6	0.86	-0.098	4.291	0.01	0.007	0	42.1	37.4	73.5	132	119	0	34	32
2015	7	15	7	23	6	0.83	-0.108	4.291	0.013	0.01	0	41.7	36.5	74.4	132	118	0	35	33
2015	7	15	7	33	6	0.863	-0.108	4.295	0.01	0.007	0	41.7	37.4	74.8	132	118	0	35	31
2015	7	15	7	43	6	0.833	-0.072	4.295	0.013	0.01	0	42.1	37.4	76.1	132	118	0	34	31
2015	7	15	7	53	6	0.81	-0.105	4.298	0.01	0.007	0	42.1	37	76.1	132	118	0	34	32
2015	7	15	8	3	6	0.899	-0.098	4.298	0.01	0.007	0	41.7	37	76.1	132	118	0	35	32
2015	7	15	8	13	6	0.817	-0.095	4.298	0.01	0.007	0	42.6	37.4	76.5	133	119	0	34	32
2015	7	15	8	23	6	0.82	-0.075	4.301	0.01	0.007	0	42.1	37	76.5	132	118	0	34	32
2015	7	15	8	33	6	0.85	-0.089	4.301	0.01	0.007	0	41.7	37.4	76.5	132	119	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	15	8	43	6	0.787	-0.079	4.301	0.01	0.007	0	42.1	37	76.5	132	118	0	34	32
2015	7	15	8	53	6	0.843	-0.098	4.301	0.01	0.007	0	41.7	37	77	131	118	0	34	32
2015	7	15	9	3	6	0.84	-0.079	4.301	0.013	0.01	0	42.1	37	76.5	132	118	0	34	32
2015	7	15	9	13	6	0.823	-0.079	4.301	0.01	0.007	0	41.7	37	75.3	132	118	0	35	32
2015	7	15	9	23	6	0.823	-0.069	4.304	0.01	0.007	0	41.7	37	76.5	131	118	0	34	32
2015	7	15	9	33	6	0.856	-0.112	4.304	0.01	0.007	0	41.7	36.5	75.7	131	117	0	34	32
2015	7	15	9	43	6	0.843	-0.131	4.304	0.013	0.01	0	41.3	37	76.1	131	118	0	35	32
2015	7	15	9	53	6	0.866	-0.115	4.304	0.01	0.007	0	41.7	37	76.5	131	118	0	34	32
2015	7	15	10	3	6	0.856	-0.098	4.308	0.01	0.007	0	41.7	37	76.1	131	118	0	34	32
2015	7	15	10	13	6	0.853	-0.108	4.308	0.01	0.007	0	41.3	36.5	76.5	131	117	0	35	32
2015	7	15	10	23	6	0.84	-0.105	4.308	0.01	0.007	0	41.3	36.5	75.7	131	117	0	35	32
2015	7	15	10	33	6	0.84	-0.098	4.308	0.01	0.007	0	41.7	36.5	75.3	131	117	0	34	32
2015	7	15	10	43	6	0.866	-0.105	4.311	0.01	0.007	0	41.7	37	75.3	131	117	0	34	31
2015	7	15	10	53	6	0.833	-0.098	4.311	0.01	0.007	0	41.7	36.5	75.7	131	117	0	34	32
2015	7	15	11	3	6	0.846	-0.095	4.311	0.01	0.007	0	41.7	36.5	75.3	131	117	0	34	32
2015	7	15	11	13	6	0.823	-0.082	4.311	0.01	0.007	0	41.7	37	75.3	131	117	0	34	31
2015	7	15	11	23	6	0.778	-0.098	4.311	0.01	0.007	0	41.7	37	74	131	117	0	34	31
2015	7	15	11	33	6	0.866	-0.098	4.314	0.01	0.007	0	41.7	37	74.8	131	118	0	34	32
2015	7	15	11	43	6	0.843	-0.102	4.314	0.01	0.007	0	41.3	36.5	74.4	130	116	0	34	31
2015	7	15	11	53	6	0.784	-0.105	4.311	0.01	0.007	0	41.3	35.7	66.2	130	116	0	34	33
2015	7	15	12	3	6	0.833	-0.121	4.314	0.013	0.01	0	41.3	36.1	61.1	130	116	0	34	32
2015	7	15	12	13	6	0.827	-0.108	4.314	0.01	0.007	0	41.3	36.1	63.2	130	116	0	34	32
2015	7	15	12	23	6	0.84	-0.066	4.314	0.01	0.007	0	40.9	35.7	60.6	129	115	0	34	32
2015	7	15	12	33	6	0.863	-0.095	4.314	0.01	0.007	0	40.9	36.1	64.9	129	116	0	34	32
2015	7	15	12	43	6	0.82	-0.102	4.314	0.01	0.007	0	40.9	35.7	63.6	129	115	0	34	32
2015	7	15	12	53	6	0.817	-0.112	4.314	0.01	0.007	0	40.9	35.7	57.2	129	115	0	34	32
2015	7	15	13	3	6	0.827	-0.102	4.314	0.013	0.01	0	40.4	35.7	61.1	128	115	0	34	32
2015	7	15	13	13	6	0.843	-0.108	4.314	0.01	0.007	0	40.4	35.7	63.6	128	114	0	34	31
2015	7	15	13	23	6	0.833	-0.105	4.318	0.01	0.007	0	40	35.3	59.8	127	114	0	34	32
2015	7	15	13	33	6	0.85	-0.098	4.314	0.01	0.007	0	40.4	35.7	65.4	128	115	0	34	32
2015	7	15	13	43	6	0.801	-0.062	4.318	0.01	0.007	0	40.4	35.3	60.2	128	114	0	34	32
2015	7	15	13	53	6	0.823	-0.098	4.318	0.013	0.01	0	40	34.8	70.5	127	113	0	34	32
2015	7	15	14	3	6	0.817	-0.098	4.318	0.01	0.007	0	40	34.8	71.8	127	113	0	34	32
2015	7	15	14	13	6	0.837	-0.118	4.318	0.01	0.007	0	39.6	35.3	60.6	126	113	0	34	31
2015	7	15	14	23	6	0.817	-0.085	4.318	0.01	0.007	0	40.4	35.7	57.6	128	114	0	34	31
2015	7	15	14	33	6	0.823	-0.121	4.318	0.01	0.007	0	40.4	35.3	56.8	128	114	0	34	32
2015	7	15	14	43	6	0.804	-0.092	4.318	0.013	0.01	0	41.3	36.1	55.5	130	115	0	34	31
2015	7	15	14	53	6	0.833	-0.079	4.318	0.016	0.013	0	40.9	35.3	55.5	129	114	0	34	32
2015	7	15	15	3	6	0.856	-0.082	4.318	0.01	0.007	0	40.4	35.7	58.9	129	115	0	35	32
2015	7	15	15	13	6	0.794	-0.102	4.318	0.01	0.007	0	40.9	36.1	56.3	129	115	0	34	31
2015	7	15	15	23	6	0.814	-0.079	4.318	0.01	0.007	0	40.9	36.1	53.8	130	115	0	35	31
2015	7	15	15	33	6	0.794	-0.112	4.318	0.01	0.007	0	41.3	36.5	56.8	130	116	0	34	31
2015	7	15	15	43	6	0.83	-0.105	4.318	0.01	0.007	0	41.7	36.5	53.3	131	116	0	34	31
2015	7	15	15	53	6	0.82	-0.075	4.321	0.01	0.007	0	42.1	37.4	55	132	118	0	34	31
2015	7	15	16	3	6	0.833	-0.112	4.318	0.01	0.007	0	41.7	37	52.9	132	117	0	35	31
2015	7	15	16	13	6	0.833	-0.092	4.318	0.01	0.007	0	42.1	37.4	52.9	132	118	0	34	31
2015	7	15	16	23	6	0.758	-0.095	4.318	0.01	0.007	0	41.3	36.5	53.8	131	116	0	35	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	15	16	33	6	0.817	-0.102	4.318	0.01	0.007	0	42.1	37	55	132	117	0	34	31
2015	7	15	16	43	6	0.83	-0.072	4.318	0.01	0.007	0	42.1	37	54.6	132	117	0	34	31
2015	7	15	16	53	6	0.81	-0.095	4.318	0.01	0.007	0	41.7	37	55.5	132	117	0	35	31
2015	7	15	17	3	6	0.86	-0.118	4.318	0.013	0.01	0	41.7	37	55.5	132	117	0	35	31
2015	7	15	17	13	6	0.814	-0.115	4.318	0.01	0.007	0	42.1	37	54.2	132	117	0	34	31
2015	7	15	17	23	6	0.814	-0.128	4.318	0.01	0.007	0	42.1	37	53.3	132	117	0	34	31
2015	7	15	17	33	6	0.801	-0.095	4.318	0.01	0.007	0	42.1	37	58.5	132	117	0	34	31
2015	7	15	17	43	6	0.761	-0.075	4.318	0.01	0.007	0	41.7	36.1	52.5	131	116	0	34	32
2015	7	15	17	53	6	0.791	-0.095	4.318	0.01	0.007	0	41.7	36.5	54.6	131	116	0	34	31
2015	7	15	18	3	6	0.801	-0.092	4.318	0.01	0.007	0	41.7	36.5	55	131	117	0	34	32
2015	7	15	18	13	6	0.778	-0.112	4.318	0.01	0.007	0	41.7	36.5	57.2	131	116	0	34	31
2015	7	15	18	23	6	0.833	-0.092	4.318	0.01	0.007	0	41.7	36.5	54.6	131	116	0	34	31
2015	7	15	18	33	6	0.797	-0.095	4.318	0.01	0.007	0	41.3	36.1	58	130	115	0	34	31
2015	7	15	18	43	6	0.804	-0.102	4.318	0.01	0.007	0	41.3	35.7	61.1	130	115	0	34	32
2015	7	15	18	53	6	0.846	-0.082	4.318	0.013	0.01	0	41.3	35.3	60.2	130	114	0	34	32
2015	7	15	19	3	6	0.801	-0.066	4.318	0.01	0.007	0	41.3	35.7	64.5	130	114	0	34	31
2015	7	15	19	13	6	0.85	-0.069	4.318	0.01	0.007	0	40.9	35.7	70.1	130	115	0	35	32
2015	7	15	19	23	6	0.791	-0.095	4.318	0.01	0.007	0	41.3	36.1	74	130	115	0	34	31
2015	7	15	19	33	6	0.801	-0.072	4.318	0.013	0.01	0	41.7	36.5	71.4	131	116	0	34	31
2015	7	15	19	43	6	0.843	-0.069	4.318	0.01	0.007	0	41.3	36.1	74.8	131	116	0	35	32
2015	7	15	19	53	6	0.83	-0.062	4.318	0.013	0.01	0	41.3	35.7	72.2	130	115	0	34	32
2015	7	15	20	3	6	0.807	-0.072	4.318	0.013	0.01	0	41.3	35.7	74.4	130	114	0	34	31
2015	7	15	20	13	6	0.817	-0.102	4.318	0.013	0.01	0	41.3	35.7	74	130	114	0	34	31
2015	7	15	20	23	6	0.846	-0.089	4.318	0.01	0.007	0	41.3	35.3	74.8	130	114	0	34	32
2015	7	15	20	33	6	0.843	-0.075	4.318	0.01	0.007	0	41.7	36.1	74	131	116	0	34	32
2015	7	15	20	43	6	0.83	-0.095	4.318	0.01	0.007	0	42.1	36.5	67.9	132	117	0	34	32
2015	7	15	20	53	6	0.837	-0.095	4.318	0.01	0.007	0	42.6	36.5	65.4	133	117	0	34	32
2015	7	15	21	3	6	0.784	-0.098	4.321	0.01	0.007	0	42.1	37	71.8	132	117	0	34	31
2015	7	15	21	13	24	0.833	-0.125	4.321	0.01	0.007	0	42.1	37.4	73.1	133	118	0	35	31
2015	7	15	21	23	24	0.784	-0.059	4.318	0.013	0.01	0	42.1	37.8	65.8	133	119	0	35	31
2015	7	15	21	33	24	0.827	-0.128	4.318	0.01	0.007	0	42.6	37.8	65.4	133	119	0	34	31
2015	7	15	21	43	24	0.83	-0.112	4.321	0.01	0.007	0	43.4	37.8	69.7	134	119	0	33	31
2015	7	15	21	53	24	0.764	-0.098	4.321	0.01	0.007	0	43	37.8	65.8	134	119	0	34	31
2015	7	15	22	3	24	0.804	-0.092	4.321	0.013	0.01	0	42.6	37.4	68.8	133	119	0	34	32
2015	7	15	22	13	24	0.784	-0.108	4.321	0.01	0.007	0	42.6	37.4	67.1	133	119	0	34	32
2015	7	15	22	23	24	0.83	-0.105	4.321	0.01	0.007	0	42.6	37	68.8	133	118	0	34	32
2015	7	15	22	33	24	0.823	-0.095	4.321	0.01	0.007	0	43	37.8	73.1	134	119	0	34	31
2015	7	15	22	43	24	0.801	-0.121	4.321	0.01	0.007	0	43	37.4	72.7	134	119	0	34	32
2015	7	15	22	53	24	0.814	-0.082	4.321	0.016	0.013	0	42.1	37.4	74	132	118	0	34	31
2015	7	15	23	3	24	0.771	-0.056	4.321	0.01	0.007	0	42.6	37.4	73.1	133	118	0	34	31
2015	7	15	23	13	24	0.807	-0.105	4.321	0.01	0.007	0	41.7	37	73.5	132	117	0	35	31
2015	7	15	23	23	24	0.804	-0.085	4.321	0.01	0.007	0	42.1	37	72.7	132	118	0	34	32
2015	7	15	23	33	24	0.853	-0.095	4.321	0.01	0.007	0	42.1	37	70.5	132	118	0	34	32
2015	7	15	23	43	24	0.784	-0.079	4.321	0.01	0.007	0	42.6	37.4	72.2	133	119	0	34	32
2015	7	15	23	53	24	0.833	-0.092	4.324	0.01	0.007	0	42.6	37.4	71.8	133	118	0	34	31
2015	7	16	0	3	24	0.846	-0.082	4.321	0.01	0.007	0	42.6	37.4	73.5	133	118	0	34	31
2015	7	16	0	13	24	0.804	-0.059	4.324	0.01	0.007	0	41.7	37.4	73.1	132	118	0	35	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	16	0	23	24	0.791	-0.082	4.324	0.01	0.007	0	42.6	37	71	133	118	0	34	32
2015	7	16	0	33	24	0.869	-0.079	4.324	0.01	0.007	0	42.6	37.4	72.7	133	118	0	34	31
2015	7	16	0	43	24	0.794	-0.092	4.324	0.01	0.007	0	42.6	37	73.1	133	118	0	34	32
2015	7	16	0	53	24	0.886	-0.092	4.324	0.01	0.007	0	42.1	36.5	73.1	132	116	0	34	31
2015	7	16	1	3	24	0.814	-0.098	4.327	0.01	0.007	0	41.7	37	69.7	131	117	0	34	31
2015	7	16	1	13	24	0.873	-0.112	4.327	0.01	0.007	0	42.1	37	72.7	132	117	0	34	31
2015	7	16	1	23	24	0.837	-0.092	4.327	0.01	0.007	0	42.1	36.5	72.7	132	117	0	34	32
2015	7	16	1	33	24	0.863	-0.118	4.327	0.01	0.007	0	42.6	36.5	71.8	133	117	0	34	32
2015	7	16	1	43	24	0.837	-0.135	4.331	0.01	0.007	0	42.1	37	72.7	132	117	0	34	31
2015	7	16	1	53	24	0.83	-0.108	4.331	0.01	0.007	0	42.6	37	73.1	133	118	0	34	32
2015	7	16	2	3	24	0.869	-0.085	4.331	0.01	0.007	0	42.1	37	72.2	132	117	0	34	31
2015	7	16	2	13	24	0.843	-0.059	4.334	0.01	0.007	0	42.1	36.5	72.7	132	117	0	34	32
2015	7	16	2	23	24	0.84	-0.089	4.334	0.01	0.007	0	41.7	36.5	73.1	131	117	0	34	32
2015	7	16	2	33	24	0.866	-0.095	4.334	0.01	0.007	0	42.1	36.5	72.2	132	117	0	34	32
2015	7	16	2	43	24	0.883	-0.082	4.334	0.01	0.007	0	42.1	36.5	73.5	132	117	0	34	32
2015	7	16	2	53	24	0.853	-0.085	4.334	0.01	0.007	0	41.7	37	73.1	131	117	0	34	31
2015	7	16	3	3	24	0.801	-0.062	4.334	0.01	0.007	0	42.6	36.5	73.5	132	117	0	33	32
2015	7	16	3	13	24	0.873	-0.072	4.334	0.01	0.007	0	42.1	36.5	69.2	132	117	0	34	32
2015	7	16	3	23	24	0.892	-0.105	4.334	0.01	0.007	0	41.7	37	73.5	132	117	0	35	31
2015	7	16	3	33	24	0.869	-0.102	4.334	0.013	0.01	0	42.1	37	73.5	132	117	0	34	31
2015	7	16	3	43	24	0.83	-0.072	4.334	0.013	0.01	0	42.1	37	73.5	132	117	0	34	31
2015	7	16	3	53	24	0.827	-0.075	4.337	0.01	0.007	0	42.1	36.5	73.5	132	117	0	34	32
2015	7	16	4	3	24	0.84	-0.056	4.334	0.01	0.007	0	42.1	37	73.1	132	118	0	34	32
2015	7	16	4	13	24	0.873	-0.121	4.334	0.01	0.007	0	42.1	37	74	132	117	0	34	31
2015	7	16	4	23	24	0.886	-0.079	4.334	0.01	0.007	0	42.1	37	74	132	117	0	34	31
2015	7	16	4	33	24	0.833	-0.115	4.334	0.013	0.01	0	42.6	37	74	133	118	0	34	32
2015	7	16	4	43	24	0.883	-0.105	4.334	0.01	0.007	0	42.1	37	74	132	118	0	34	32
2015	7	16	4	53	24	0.879	-0.102	4.334	0.01	0.007	0	42.6	37.4	74	133	118	0	34	31
2015	7	16	5	3	24	0.846	-0.108	4.334	0.01	0.007	0	42.6	37	73.5	133	118	0	34	32
2015	7	16	5	13	24	0.83	-0.072	4.334	0.01	0.007	0	42.6	37.4	72.7	133	118	0	34	31
2015	7	16	5	23	24	0.846	-0.102	4.334	0.01	0.007	0	42.6	37	74.4	133	118	0	34	32
2015	7	16	5	33	24	0.84	-0.072	4.334	0.01	0.007	0	42.6	37.8	74	133	119	0	34	31
2015	7	16	5	43	24	0.837	-0.092	4.334	0.01	0.007	0	42.6	37.8	72.7	133	119	0	34	31
2015	7	16	5	53	24	0.794	-0.066	4.334	0.01	0.007	0	42.1	37.4	74	133	119	0	35	32
2015	7	16	6	3	24	0.843	-0.062	4.334	0.01	0.007	0	42.1	37	74	133	118	0	35	32
2015	7	16	6	13	24	0.863	-0.118	4.334	0.01	0.007	0	42.6	37.8	74.4	133	119	0	34	31
2015	7	16	6	23	24	0.86	-0.095	4.334	0.01	0.007	0	42.6	37.4	74	133	118	0	34	31
2015	7	16	6	33	24	0.873	-0.079	4.334	0.01	0.007	0	42.1	37.4	74.4	132	118	0	34	31
2015	7	16	6	43	24	0.873	-0.056	4.334	0.01	0.007	0	42.1	37	74.8	132	118	0	34	32
2015	7	16	6	53	24	0.817	-0.082	4.334	0.01	0.007	0	42.1	37	74	132	118	0	34	32
2015	7	16	7	3	24	0.83	-0.079	4.334	0.013	0.01	0	42.1	37	75.3	133	118	0	35	32
2015	7	16	7	13	24	0.791	-0.072	4.334	0.01	0.007	0	42.6	37.4	74.4	133	118	0	34	31
2015	7	16	7	23	24	0.83	-0.079	4.334	0.01	0.007	0	42.6	37	74.8	133	118	0	34	32
2015	7	16	7	33	24	0.83	-0.069	4.334	0.013	0.01	0	42.6	37.4	74.4	133	118	0	34	31
2015	7	16	7	43	24	0.827	-0.098	4.334	0.01	0.007	0	42.1	37.4	75.3	132	118	0	34	31
2015	7	16	7	53	24	0.856	-0.079	4.334	0.013	0.01	0	41.7	37.4	74.4	132	118	0	35	31
2015	7	16	8	3	24	0.843	-0.098	4.334	0.01	0.007	0	42.6	37.4	74.4	133	119	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	16	8	13	24	0.853	-0.095	4.331	0.013	0.01	0	42.1	37.4	74.4	132	118	0	34	31
2015	7	16	8	23	24	0.902	-0.112	4.331	0.01	0.007	0	41.7	37	74.4	131	117	0	34	31
2015	7	16	8	33	24	0.81	-0.072	4.331	0.016	0.013	0	42.1	36.5	74.8	132	117	0	34	32
2015	7	16	8	43	24	0.82	-0.092	4.331	0.01	0.007	0	41.7	36.1	73.5	131	116	0	34	32
2015	7	16	8	53	24	0.853	-0.102	4.331	0.01	0.007	0	41.3	36.5	74	130	117	0	34	32
2015	7	16	9	3	24	0.814	-0.102	4.331	0.01	0.007	0	41.3	36.1	74	131	116	0	35	32
2015	7	16	9	13	24	0.817	-0.105	4.331	0.01	0.007	0	41.7	36.5	73.5	131	117	0	34	32
2015	7	16	9	23	24	0.823	-0.108	4.327	0.01	0.007	0	41.3	36.5	73.1	130	116	0	34	31
2015	7	16	9	33	24	0.84	-0.079	4.327	0.01	0.007	0	41.3	36.5	71.4	131	117	0	35	32
2015	7	16	9	43	24	0.814	-0.075	4.321	0.013	0.01	0	41.7	36.5	64.5	131	117	0	34	32
2015	7	16	9	53	24	0.814	-0.108	4.321	0.01	0.007	0	41.3	37	64.9	131	117	0	35	31
2015	7	16	10	3	24	0.814	-0.118	4.318	0.01	0.007	0	41.7	36.5	70.1	131	117	0	34	32
2015	7	16	10	13	24	0.843	-0.079	4.318	0.01	0.007	0	41.7	36.5	71	131	117	0	34	32
2015	7	16	10	23	24	0.817	-0.079	4.318	0.013	0.01	0	41.3	37	72.7	131	117	0	35	31
2015	7	16	10	33	24	0.84	-0.115	4.318	0.01	0.007	0	41.3	36.5	64.1	131	117	0	35	32
2015	7	16	10	43	24	0.807	-0.082	4.314	0.01	0.007	0	41.7	36.5	66.2	131	117	0	34	32
2015	7	16	10	53	24	0.804	-0.118	4.314	0.01	0.007	0	41.7	36.1	65.4	131	116	0	34	32
2015	7	16	11	3	24	0.856	-0.095	4.314	0.01	0.007	0	41.7	37	61.1	132	118	0	35	32
2015	7	16	11	13	24	0.843	-0.092	4.314	0.01	0.007	0	41.7	37	58.5	131	117	0	34	31
2015	7	16	11	23	24	0.791	-0.089	4.314	0.01	0.007	0	40.9	36.5	59.8	130	116	0	35	31
2015	7	16	11	33	24	0.843	-0.072	4.314	0.01	0.007	0	41.3	36.1	61.1	130	116	0	34	32
2015	7	16	11	43	24	0.817	-0.105	4.314	0.01	0.007	0	41.3	36.5	74	130	116	0	34	31
2015	7	16	11	53	24	0.804	-0.108	4.311	0.01	0.007	0	41.3	36.1	70.5	130	116	0	34	32
2015	7	16	12	3	24	0.784	-0.112	4.311	0.01	0.007	0	41.3	36.1	66.7	130	116	0	34	32
2015	7	16	12	13	24	0.846	-0.095	4.311	0.01	0.007	0	41.3	35.7	66.7	130	115	0	34	32
2015	7	16	12	23	24	0.794	-0.092	4.311	0.01	0.007	0	41.3	36.1	63.2	130	116	0	34	32
2015	7	16	12	33	24	0.856	-0.062	4.311	0.01	0.007	0	41.3	36.1	60.6	130	115	0	34	31
2015	7	16	12	43	24	0.774	-0.079	4.311	0.01	0.007	0	41.3	36.5	66.2	130	116	0	34	31
2015	7	16	12	53	24	0.794	-0.092	4.311	0.013	0.01	0	40.9	35.7	60.6	129	115	0	34	32
2015	7	16	13	3	24	0.846	-0.095	4.311	0.013	0.01	0	40.4	35.3	65.8	129	114	0	35	32
2015	7	16	13	13	24	0.801	-0.095	4.311	0.01	0.007	0	40.9	35.3	59.3	129	114	0	34	32
2015	7	16	13	23	24	0.843	-0.118	4.311	0.01	0.007	0	40.9	35.7	61.1	129	114	0	34	31
2015	7	16	13	33	24	0.814	-0.098	4.308	0.01	0.007	0	40.9	35.7	63.2	129	114	0	34	31
2015	7	16	13	43	24	0.837	-0.095	4.308	0.01	0.007	0	40.4	35.7	65.4	128	114	0	34	31
2015	7	16	13	53	24	0.801	-0.089	4.308	0.013	0.01	0	40.4	35.3	58	128	114	0	34	32
2015	7	16	14	3	24	0.797	-0.095	4.308	0.016	0.013	0	40.4	35.3	61.1	128	114	0	34	32
2015	7	16	14	13	24	0.823	-0.079	4.308	0.01	0.007	0	40.9	36.1	55.9	129	115	0	34	31
2015	7	16	14	23	24	0.82	-0.102	4.308	0.01	0.007	0	40.9	36.1	54.6	129	115	0	34	31
2015	7	16	14	33	24	0.768	-0.089	4.304	0.01	0.007	0	40.9	36.1	58.5	129	115	0	34	31
2015	7	16	14	43	24	0.771	-0.115	4.304	0.01	0.007	0	40	35.7	55.5	128	114	0	35	31
2015	7	16	14	53	24	0.83	-0.095	4.304	0.013	0.01	0	40.4	35.3	60.6	128	114	0	34	32
2015	7	16	15	3	24	0.82	-0.082	4.304	0.013	0.01	0	40.9	36.1	55.9	129	115	0	34	31
2015	7	16	15	13	24	0.804	-0.105	4.301	0.01	0.007	0	40.9	36.1	50.7	129	115	0	34	31
2015	7	16	15	23	24	0.817	-0.108	4.298	0.01	0.007	0	40.9	35.7	52	129	114	0	34	31
2015	7	16	15	33	24	0.801	-0.092	4.298	0.013	0.01	0	40.9	36.1	58.5	129	115	0	34	31
2015	7	16	15	43	24	0.84	-0.089	4.298	0.01	0.007	0	41.3	36.5	57.2	130	116	0	34	31
2015	7	16	15	53	24	0.778	-0.102	4.298	0.01	0.007	0	40.9	36.5	53.8	130	116	0	35	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	16	16	3	24	0.771	-0.092	4.298	0.01	0.007	0	41.3	36.1	55	130	115	0	34	31
2015	7	16	16	13	24	0.807	-0.089	4.295	0.01	0.007	0	41.3	35.7	51.2	130	115	0	34	32
2015	7	16	16	23	24	0.83	-0.112	4.291	0.01	0.007	0	41.3	36.5	54.6	130	116	0	34	31
2015	7	16	16	33	24	0.817	-0.125	4.288	0.01	0.007	0	41.7	37	55.5	131	117	0	34	31
2015	7	16	16	43	24	0.787	-0.102	4.291	0.01	0.007	0	41.3	36.5	54.6	130	116	0	34	31
2015	7	16	16	53	24	0.83	-0.082	4.291	0.016	0.013	0	40.9	36.5	51.2	129	116	0	34	31
2015	7	16	17	3	24	0.804	-0.062	4.288	0.01	0.007	0	41.3	36.5	53.3	130	116	0	34	31
2015	7	16	17	13	24	0.787	-0.102	4.288	0.013	0.01	0	41.3	36.1	54.2	130	115	0	34	31
2015	7	16	17	23	24	0.774	-0.115	4.288	0.01	0.007	0	41.3	36.1	52.9	130	115	0	34	31
2015	7	16	17	33	24	0.781	-0.056	4.288	0.013	0.01	0	41.3	36.1	51.6	130	116	0	34	32
2015	7	16	17	43	24	0.83	-0.079	4.285	0.01	0.007	0	40.9	36.1	53.8	130	116	0	35	32
2015	7	16	17	53	24	0.758	-0.079	4.281	0.01	0.007	0	41.3	36.5	59.8	130	116	0	34	31
2015	7	16	18	3	24	0.82	-0.105	4.285	0.013	0.01	0	41.3	36.1	51.2	130	116	0	34	32
2015	7	16	18	13	24	0.814	-0.098	4.281	0.013	0.01	0	41.3	36.1	60.6	130	115	0	34	31
2015	7	16	18	23	24	0.846	-0.082	4.281	0.01	0.007	0	40.9	36.1	64.1	129	115	0	34	31
2015	7	16	18	33	24	0.81	-0.075	4.281	0.013	0.01	0	41.7	36.5	63.6	131	116	0	34	31
2015	7	16	18	43	24	0.787	-0.125	4.281	0.013	0.01	0	41.3	36.5	65.4	130	116	0	34	31
2015	7	16	18	53	24	0.804	-0.121	4.281	0.01	0.007	0	41.3	36.5	71.8	130	116	0	34	31
2015	7	16	19	3	24	0.853	-0.105	4.281	0.01	0.007	0	41.7	36.5	71.8	131	116	0	34	31
2015	7	16	19	13	24	0.804	-0.115	4.281	0.01	0.007	0	41.7	36.5	74.8	131	116	0	34	31
2015	7	16	19	23	24	0.807	-0.079	4.281	0.01	0.007	0	42.1	37	75.3	132	117	0	34	31
2015	7	16	19	33	24	0.82	-0.079	4.278	0.01	0.007	0	41.7	37	71.4	131	117	0	34	31
2015	7	16	19	43	24	0.781	-0.066	4.278	0.01	0.007	0	41.3	36.5	71	130	116	0	34	31
2015	7	16	19	53	24	0.817	-0.102	4.278	0.01	0.007	0	41.7	36.5	70.1	131	117	0	34	32
2015	7	16	20	3	24	0.787	-0.092	4.278	0.01	0.007	0	41.7	36.5	74.4	131	117	0	34	32
2015	7	16	20	13	24	0.83	-0.115	4.278	0.013	0.01	0	42.1	37	72.2	132	117	0	34	31
2015	7	16	20	23	24	0.83	-0.121	4.278	0.01	0.007	0	41.7	37	71.8	131	117	0	34	31
2015	7	16	20	33	24	0.814	-0.098	4.278	0.01	0.007	0	42.1	36.5	66.2	132	117	0	34	32
2015	7	16	20	43	24	0.797	-0.098	4.278	0.013	0.01	0	41.7	37.4	64.1	131	118	0	34	31
2015	7	16	20	53	24	0.837	-0.085	4.278	0.013	0.01	0	43	37	70.5	133	118	0	33	32
2015	7	16	21	3	24	0.82	-0.108	4.278	0.01	0.007	0	43	37.8	71	133	119	0	33	31
2015	7	16	21	13	24	0.827	-0.095	4.278	0.013	0.01	0	42.6	37.4	68.8	133	118	0	34	31
2015	7	16	21	23	24	0.807	-0.082	4.278	0.01	0.007	0	40.9	37.8	57.6	129	118	0	34	30
2015	7	16	21	33	24	0.82	-0.079	4.278	0.01	0.007	0	42.6	37.4	56.8	133	118	0	34	31
2015	7	16	21	43	24	0.794	-0.069	4.278	0.013	0.01	0	43	37.8	58.9	134	119	0	34	31
2015	7	16	21	53	24	0.827	-0.108	4.278	0.01	0.007	0	42.6	37.4	74.8	133	118	0	34	31
2015	7	16	22	3	24	0.771	-0.089	4.278	0.013	0.01	0	42.1	36.5	75.3	132	117	0	34	32
2015	7	16	22	13	24	0.787	-0.125	4.278	0.01	0.007	0	42.1	37	65.4	132	117	0	34	31
2015	7	16	22	23	24	0.787	-0.079	4.278	0.013	0.01	0	42.1	37	64.5	132	117	0	34	31
2015	7	16	22	33	24	0.846	-0.082	4.278	0.01	0.007	0	42.1	37	73.5	132	118	0	34	32
2015	7	16	22	43	24	0.82	-0.082	4.278	0.013	0.01	0	42.1	37.4	73.5	132	118	0	34	31
2015	7	16	22	53	24	0.768	-0.108	4.278	0.013	0.01	0	42.6	37.4	66.2	133	118	0	34	31
2015	7	16	23	3	24	0.784	-0.112	4.278	0.01	0.007	0	42.1	36.5	65.8	132	117	0	34	32
2015	7	16	23	13	24	0.771	-0.062	4.275	0.013	0.01	0	42.1	36.5	64.1	132	116	0	34	31
2015	7	16	23	23	24	0.738	-0.098	4.278	0.01	0.007	0	41.7	37	62.8	132	118	0	35	32
2015	7	16	23	33	24	0.804	-0.079	4.275	0.01	0.007	0	42.1	37	64.1	132	117	0	34	31
2015	7	16	23	43	24	0.846	-0.079	4.275	0.01	0.007	0	41.7	36.5	64.5	132	117	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	16	23	53	24	0.81	-0.102	4.278	0.01	0.007	0	42.1	36.5	73.1	132	117	0	34	32
2015	7	17	0	3	24	0.814	-0.066	4.278	0.01	0.007	0	42.1	37	71.8	132	117	0	34	31
2015	7	17	0	13	24	0.833	-0.089	4.275	0.01	0.007	0	42.1	37	68.4	132	117	0	34	31
2015	7	17	0	23	24	0.758	-0.089	4.278	0.01	0.007	0	42.6	37.4	72.7	133	118	0	34	31
2015	7	17	0	33	24	0.801	-0.085	4.278	0.01	0.007	0	42.1	37	69.2	132	118	0	34	32
2015	7	17	0	43	24	0.778	-0.075	4.278	0.013	0.01	0	42.6	37.4	75.3	133	118	0	34	31
2015	7	17	0	53	24	0.833	-0.075	4.278	0.013	0.01	0	42.1	37	75.3	133	118	0	35	32
2015	7	17	1	3	24	0.82	-0.095	4.278	0.013	0.01	0	42.1	37	75.7	132	118	0	34	32
2015	7	17	1	13	24	0.879	-0.072	4.275	0.01	0.007	0	41.7	36.5	74.4	132	117	0	35	32
2015	7	17	1	23	24	0.774	-0.105	4.278	0.01	0.007	0	42.6	37.4	74.8	133	118	0	34	31
2015	7	17	1	33	24	0.784	-0.062	4.278	0.01	0.007	0	42.1	37.4	74.8	133	118	0	35	31
2015	7	17	1	43	24	0.817	-0.108	4.278	0.013	0.01	0	42.1	37	75.3	132	118	0	34	32
2015	7	17	1	53	24	0.863	-0.105	4.278	0.01	0.007	0	42.1	36.5	75.7	132	117	0	34	32
2015	7	17	2	3	24	0.784	-0.062	4.278	0.01	0.007	0	42.1	37	76.1	132	118	0	34	32
2015	7	17	2	13	24	0.863	-0.095	4.278	0.01	0.007	0	42.1	36.5	76.1	132	117	0	34	32
2015	7	17	2	23	24	0.843	-0.112	4.278	0.013	0.01	0	42.1	36.5	74.8	132	117	0	34	32
2015	7	17	2	33	24	0.83	-0.115	4.278	0.013	0.01	0	42.1	37	74.4	132	117	0	34	31
2015	7	17	2	43	24	0.863	-0.108	4.278	0.01	0.007	0	42.1	36.5	75.3	132	117	0	34	32
2015	7	17	2	53	24	0.837	-0.112	4.278	0.01	0.007	0	42.6	37.4	75.3	133	118	0	34	31
2015	7	17	3	3	24	0.846	-0.089	4.278	0.013	0.01	0	42.6	37	75.3	133	118	0	34	32
2015	7	17	3	13	24	0.853	-0.062	4.278	0.01	0.007	0	42.6	37.4	75.7	133	118	0	34	31
2015	7	17	3	23	24	0.814	-0.105	4.275	0.01	0.007	0	42.1	36.5	75.3	132	117	0	34	32
2015	7	17	3	33	24	0.863	-0.098	4.278	0.01	0.007	0	42.1	36.5	75.3	132	117	0	34	32
2015	7	17	3	43	24	0.853	-0.095	4.275	0.01	0.007	0	42.6	37.4	75.3	133	118	0	34	31
2015	7	17	3	53	24	0.837	-0.095	4.278	0.01	0.007	0	42.6	37	75.7	133	118	0	34	32
2015	7	17	4	3	24	0.827	-0.075	4.278	0.01	0.007	0	42.1	36.5	75.7	132	117	0	34	32
2015	7	17	4	13	24	0.86	-0.075	4.275	0.013	0.01	0	42.6	37	75.3	133	118	0	34	32
2015	7	17	4	23	24	0.804	-0.102	4.275	0.01	0.007	0	42.6	37.4	74.8	133	118	0	34	31
2015	7	17	4	33	24	0.869	-0.079	4.275	0.01	0.007	0	41.7	36.5	75.3	132	117	0	35	32
2015	7	17	4	43	24	0.889	-0.079	4.275	0.01	0.007	0	41.7	37.4	74.8	132	118	0	35	31
2015	7	17	4	53	24	0.82	-0.112	4.275	0.016	0.013	0	42.1	37	74.4	132	117	0	34	31
2015	7	17	5	3	24	0.81	-0.095	4.275	0.01	0.007	0	42.1	37	75.3	132	118	0	34	32
2015	7	17	5	13	24	0.82	-0.079	4.275	0.01	0.007	0	42.1	37	75.7	132	117	0	34	31
2015	7	17	5	23	24	0.856	-0.098	4.275	0.01	0.007	0	42.6	37.4	74.8	133	118	0	34	31
2015	7	17	5	33	24	0.863	-0.095	4.275	0.01	0.007	0	43	37.4	75.3	133	118	0	33	31
2015	7	17	5	43	24	0.814	-0.108	4.275	0.01	0.007	0	42.1	37.4	74.8	132	118	0	34	31
2015	7	17	5	53	24	0.84	-0.098	4.275	0.013	0.01	0	42.6	37.4	75.3	133	118	0	34	31
2015	7	17	6	3	24	0.843	-0.102	4.275	0.013	0.01	0	42.6	37	74.8	133	118	0	34	32
2015	7	17	6	13	24	0.837	-0.102	4.275	0.01	0.007	0	42.1	36.5	75.7	132	117	0	34	32
2015	7	17	6	23	24	0.843	-0.092	4.275	0.01	0.007	0	42.6	37	75.7	133	118	0	34	32
2015	7	17	6	33	24	0.778	-0.059	4.272	0.01	0.007	0	42.6	37.4	75.7	133	118	0	34	31
2015	7	17	6	43	24	0.84	-0.085	4.272	0.013	0.01	0	42.6	37.4	75.7	133	118	0	34	31
2015	7	17	6	53	24	0.817	-0.115	4.272	0.013	0.01	0	42.6	37	74.8	133	118	0	34	32
2015	7	17	7	3	24	0.84	-0.102	4.272	0.01	0.007	0	42.6	37	74.8	133	118	0	34	32
2015	7	17	7	13	24	0.83	-0.112	4.272	0.01	0.007	0	42.1	36.5	75.3	132	117	0	34	32
2015	7	17	7	23	24	0.82	-0.108	4.272	0.01	0.007	0	42.1	36.5	75.3	132	117	0	34	32
2015	7	17	7	33	24	0.853	-0.095	4.272	0.01	0.007	0	42.1	37	75.3	132	117	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	17	7	43	24	0.814	-0.075	4.272	0.016	0.013	0	42.1	37	75.3	133	118	0	35	32
2015	7	17	7	53	24	0.879	-0.102	4.272	0.01	0.007	0	42.1	36.5	74.4	132	117	0	34	32
2015	7	17	8	3	24	0.86	-0.105	4.272	0.013	0.01	0	41.7	36.1	76.1	132	117	0	35	33
2015	7	17	8	13	24	0.784	-0.062	4.272	0.016	0.013	0	42.1	36.5	75.7	132	117	0	34	32
2015	7	17	8	23	24	0.856	-0.118	4.272	0.01	0.007	0	42.1	37	74.8	133	118	0	35	32
2015	7	17	8	33	24	0.82	-0.102	4.272	0.01	0.007	0	42.6	37.4	75.3	133	119	0	34	32
2015	7	17	8	43	24	0.84	-0.108	4.268	0.01	0.007	0	42.1	36.5	74.8	132	117	0	34	32
2015	7	17	8	53	24	0.823	-0.092	4.268	0.01	0.007	0	42.1	36.5	75.7	132	117	0	34	32
2015	7	17	9	3	24	0.85	-0.066	4.268	0.016	0.013	0	42.6	37	76.1	133	118	0	34	32
2015	7	17	9	13	24	0.846	-0.095	4.268	0.01	0.007	0	42.6	37.4	75.7	133	118	0	34	31
2015	7	17	9	23	24	0.843	-0.082	4.268	0.01	0.007	0	42.6	37.4	76.1	133	118	0	34	31
2015	7	17	9	33	24	0.85	-0.125	4.268	0.01	0.007	0	42.1	37	76.1	133	118	0	35	32
2015	7	17	9	43	24	0.843	-0.115	4.268	0.01	0.007	0	42.6	37	76.5	133	118	0	34	32
2015	7	17	9	53	24	0.82	-0.095	4.268	0.01	0.007	0	42.1	37.8	75.7	133	119	0	35	31
2015	7	17	10	3	24	0.823	-0.125	4.268	0.01	0.007	0	43	37.4	76.1	134	119	0	34	32
2015	7	17	10	13	24	0.869	-0.118	4.268	0.01	0.007	0	42.6	37.4	76.1	133	119	0	34	32
2015	7	17	10	23	24	0.791	-0.108	4.268	0.01	0.007	0	42.6	37.4	73.5	134	119	0	35	32
2015	7	17	10	33	24	0.896	-0.135	4.268	0.01	0.007	0	43	37.4	75.3	134	119	0	34	32
2015	7	17	10	43	24	0.827	-0.069	4.268	0.01	0.007	0	42.6	37	71.8	133	118	0	34	32
2015	7	17	10	53	24	0.807	-0.079	4.265	0.013	0.01	0	42.6	37.4	67.5	133	119	0	34	32
2015	7	17	11	3	24	0.807	-0.098	4.265	0.01	0.007	0	41.7	37	67.5	132	118	0	35	32
2015	7	17	11	13	24	0.797	-0.108	4.265	0.016	0.013	0	42.1	37	67.5	132	118	0	34	32
2015	7	17	11	23	24	0.82	-0.092	4.265	0.013	0.01	0	41.7	36.5	64.9	131	117	0	34	32
2015	7	17	11	33	24	0.827	-0.095	4.265	0.01	0.007	0	41.7	36.5	66.7	131	116	0	34	31
2015	7	17	11	43	24	0.837	-0.095	4.265	0.01	0.007	0	41.7	37	63.2	131	117	0	34	31
2015	7	17	11	53	24	0.86	-0.095	4.265	0.01	0.007	0	41.7	37	64.5	132	118	0	35	32
2015	7	17	12	3	24	0.827	-0.079	4.265	0.01	0.007	0	41.7	36.5	62.8	131	117	0	34	32
2015	7	17	12	13	24	0.814	-0.108	4.265	0.01	0.007	0	41.7	37	58	131	117	0	34	31
2015	7	17	12	23	24	0.781	-0.115	4.265	0.013	0.01	0	41.7	37	60.6	132	117	0	35	31
2015	7	17	12	33	24	0.833	-0.098	4.262	0.01	0.007	0	42.1	37.4	56.3	132	118	0	34	31
2015	7	17	12	43	24	0.843	-0.112	4.262	0.01	0.007	0	42.1	36.5	63.2	132	117	0	34	32
2015	7	17	12	53	24	0.833	-0.089	4.262	0.01	0.007	0	42.1	37	57.2	132	117	0	34	31
2015	7	17	13	3	24	0.843	-0.118	4.262	0.01	0.007	0	41.7	36.5	59.3	131	117	0	34	32
2015	7	17	13	13	24	0.794	-0.069	4.259	0.01	0.007	0	42.1	37	50.7	132	118	0	34	32
2015	7	17	13	23	24	0.784	-0.115	4.259	0.01	0.007	0	43	38.3	52.5	134	120	0	34	31
2015	7	17	13	33	24	0.801	-0.105	4.255	0.01	0.007	0	43.4	37.8	52.5	135	120	0	34	32
2015	7	17	13	43	24	0.833	-0.095	4.255	0.01	0.007	0	43	37.8	56.8	134	120	0	34	32
2015	7	17	13	53	24	0.787	-0.092	4.252	0.01	0.007	0	43	38.3	52	135	121	0	35	32
2015	7	17	14	3	24	0.791	-0.105	4.252	0.013	0.01	0	43.4	37.8	52.9	135	120	0	34	32
2015	7	17	14	13	24	0.784	-0.102	4.252	0.01	0.007	0	42.6	37.8	53.8	134	120	0	35	32
2015	7	17	14	23	24	0.787	-0.092	4.249	0.013	0.01	0	43	38.3	53.3	134	120	0	34	31
2015	7	17	14	33	24	0.781	-0.089	4.249	0.01	0.007	0	43.4	38.3	51.6	135	120	0	34	31
2015	7	17	14	43	24	0.794	-0.092	4.245	0.01	0.007	0	43	38.3	55.9	134	120	0	34	31
2015	7	17	14	53	24	0.738	-0.102	4.245	0.01	0.007	0	43	38.3	52.9	134	120	0	34	31
2015	7	17	15	3	24	0.82	-0.062	4.245	0.01	0.007	0	43.4	38.3	55	135	121	0	34	32
2015	7	17	15	13	24	0.804	-0.095	4.245	0.01	0.007	0	43	37.4	52.9	134	120	0	34	33
2015	7	17	15	23	24	0.784	-0.112	4.245	0.01	0.007	0	43	37.8	52.9	134	120	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	17	15	33	24	0.81	-0.112	4.242	0.013	0.01	0	43	37.8	52.9	134	120	0	34	32
2015	7	17	15	43	24	0.82	-0.085	4.245	0.01	0.007	0	43	38.3	52	134	120	0	34	31
2015	7	17	15	53	24	0.755	-0.082	4.242	0.01	0.007	0	43	37.8	52	134	120	0	34	32
2015	7	17	16	3	24	0.774	-0.095	4.239	0.01	0.007	0	42.6	37.8	56.8	133	119	0	34	31
2015	7	17	16	13	24	0.817	-0.069	4.242	0.01	0.007	0	43	37.4	53.3	134	119	0	34	32
2015	7	17	16	23	24	0.787	-0.072	4.239	0.01	0.007	0	43	37.8	55	134	120	0	34	32
2015	7	17	16	33	24	0.81	-0.118	4.239	0.01	0.007	0	43	37.4	55	134	119	0	34	32
2015	7	17	16	43	24	0.791	-0.095	4.239	0.01	0.007	0	42.6	37.4	55	133	119	0	34	32
2015	7	17	16	53	24	0.82	-0.092	4.239	0.01	0.007	0	42.6	37.8	52.9	133	119	0	34	31
2015	7	17	17	3	24	0.764	-0.112	4.239	0.013	0.01	0	42.6	37.4	53.3	133	118	0	34	31
2015	7	17	17	13	24	0.804	-0.079	4.239	0.01	0.007	0	42.6	37.4	55	133	118	0	34	31
2015	7	17	17	23	24	0.801	-0.092	4.236	0.013	0.01	0	42.6	37.4	52.9	133	119	0	34	32
2015	7	17	17	33	24	0.778	-0.085	4.236	0.01	0.007	0	42.6	37.4	55.5	133	118	0	34	31
2015	7	17	17	43	24	0.761	-0.108	4.236	0.01	0.007	0	42.6	37.4	54.6	133	118	0	34	31
2015	7	17	17	53	24	0.758	-0.089	4.236	0.01	0.007	0	42.6	37	57.2	133	118	0	34	32
2015	7	17	18	3	24	0.768	-0.092	4.236	0.016	0.013	0	41.7	37	54.6	132	117	0	35	31
2015	7	17	18	13	24	0.801	-0.095	4.236	0.01	0.007	0	42.1	36.5	55.5	132	117	0	34	32
2015	7	17	18	23	24	0.817	-0.095	4.236	0.01	0.007	0	42.1	37	60.6	133	117	0	35	31
2015	7	17	18	33	24	0.768	-0.089	4.236	0.01	0.007	0	42.1	36.5	56.8	132	117	0	34	32
2015	7	17	18	43	24	0.807	-0.095	4.236	0.01	0.007	0	42.6	37	56.8	133	118	0	34	32
2015	7	17	18	53	24	0.774	-0.121	4.236	0.01	0.007	0	42.1	36.5	56.3	132	117	0	34	32
2015	7	17	19	3	24	0.801	-0.082	4.232	0.013	0.01	0	41.7	36.5	58	131	117	0	34	32
2015	7	17	19	13	24	0.82	-0.095	4.232	0.01	0.007	0	41.7	37	57.6	132	117	0	35	31
2015	7	17	19	23	24	0.771	-0.092	4.236	0.016	0.013	0	41.7	37	57.2	132	117	0	35	31
2015	7	17	19	33	24	0.784	-0.095	4.232	0.01	0.007	0	42.1	36.1	59.8	132	116	0	34	32
2015	7	17	19	43	24	0.823	-0.112	4.232	0.01	0.007	0	42.1	36.1	72.2	132	116	0	34	32
2015	7	17	19	53	24	0.781	-0.066	4.232	0.01	0.007	0	41.7	36.5	72.2	131	116	0	34	31
2015	7	17	20	3	24	0.823	-0.066	4.236	0.01	0.007	0	42.1	36.1	76.1	132	116	0	34	32
2015	7	17	20	13	24	0.853	-0.075	4.232	0.013	0.01	0	41.7	36.1	75.3	131	116	0	34	32
2015	7	17	20	23	24	0.801	-0.121	4.236	0.01	0.007	0	41.7	36.1	76.5	131	116	0	34	32
2015	7	17	20	33	24	0.846	-0.115	4.236	0.01	0.007	0	42.6	37.4	76.5	134	119	0	35	32
2015	7	17	20	43	24	0.82	-0.108	4.232	0.01	0.007	0	43	37.8	75.3	134	119	0	34	31
2015	7	17	20	53	24	0.787	-0.062	4.236	0.01	0.007	0	43	37.8	76.1	134	119	0	34	31
2015	7	17	21	3	24	0.833	-0.131	4.236	0.01	0.007	0	42.6	37.4	73.1	133	119	0	34	32
2015	7	17	21	13	24	0.797	-0.089	4.236	0.01	0.007	0	43	37	74.8	133	118	0	33	32
2015	7	17	21	23	24	0.833	-0.062	4.236	0.01	0.007	0	42.1	37	76.5	132	118	0	34	32
2015	7	17	21	33	24	0.807	-0.089	4.232	0.01	0.007	0	42.1	36.5	74	132	117	0	34	32
2015	7	17	21	43	24	0.801	-0.098	4.232	0.01	0.007	0	42.1	37	69.2	132	117	0	34	31
2015	7	17	21	53	24	0.817	-0.079	4.232	0.01	0.007	0	42.1	36.5	63.6	132	117	0	34	32
2015	7	17	22	3	24	0.771	-0.066	4.232	0.01	0.007	0	42.6	37	62.4	133	118	0	34	32
2015	7	17	22	13	24	0.801	-0.095	4.232	0.01	0.007	0	42.6	37.4	66.2	133	118	0	34	31
2015	7	17	22	23	24	0.817	-0.121	4.232	0.01	0.007	0	42.1	36.5	64.1	132	117	0	34	32
2015	7	17	22	33	24	0.794	-0.079	4.236	0.01	0.007	0	42.6	37.4	57.2	133	118	0	34	31
2015	7	17	22	43	24	0.801	-0.095	4.236	0.01	0.007	0	42.6	37.4	59.3	132	118	0	33	31
2015	7	17	22	53	24	0.81	-0.118	4.232	0.01	0.007	0	42.1	37	61.5	132	118	0	34	32
2015	7	17	23	3	24	0.801	-0.059	4.236	0.01	0.007	0	42.1	37	64.5	132	118	0	34	32
2015	7	17	23	13	24	0.784	-0.062	4.236	0.016	0.013	0	43	37.4	70.1	133	119	0	33	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	17	23	23	24	0.823	-0.082	4.236	0.01	0.007	0	42.6	37.4	64.1	133	118	0	34	31
2015	7	17	23	33	24	0.801	-0.085	4.232	0.01	0.007	0	46.4	41.3	56.3	142	127	0	34	31
2015	7	17	23	43	24	0.791	-0.112	4.232	0.01	0.007	0	43.4	37.8	71.4	135	120	0	34	32
2015	7	17	23	53	24	0.781	-0.121	4.236	0.01	0.007	0	42.6	37.8	66.7	134	120	0	35	32
2015	7	18	0	3	24	0.797	-0.112	4.236	0.01	0.007	0	42.6	37.4	66.2	133	118	0	34	31
2015	7	18	0	13	24	0.745	-0.102	4.232	0.01	0.007	0	43	37.8	62.4	134	119	0	34	31
2015	7	18	0	23	24	0.81	-0.095	4.236	0.01	0.007	0	42.6	37.4	74.8	133	118	0	34	31
2015	7	18	0	33	24	0.784	-0.082	4.232	0.01	0.007	0	42.6	37.4	62.4	133	118	0	34	31
2015	7	18	0	43	24	0.774	-0.115	4.236	0.01	0.007	0	42.1	37.4	61.5	133	119	0	35	32
2015	7	18	0	53	24	0.784	-0.144	4.236	0.013	0.01	0	43	37	55.9	134	118	0	34	32
2015	7	18	1	3	24	0.758	-0.072	4.236	0.01	0.007	0	42.6	37.8	71.8	134	119	0	35	31
2015	7	18	1	13	24	0.781	-0.098	4.236	0.01	0.007	0	42.6	37.4	67.1	133	118	0	34	31
2015	7	18	1	23	24	0.804	-0.059	4.232	0.016	0.016	0	42.6	37.8	64.5	133	119	0	34	31
2015	7	18	1	33	24	0.846	-0.095	4.236	0.01	0.007	0	41.7	37.4	75.3	132	118	0	35	31
2015	7	18	1	43	24	0.768	-0.089	4.236	0.01	0.007	0	43	37.4	76.1	134	119	0	34	32
2015	7	18	1	53	24	0.807	-0.079	4.236	0.01	0.007	0	42.6	37.4	75.3	133	118	0	34	31
2015	7	18	2	3	24	0.817	-0.075	4.236	0.01	0.007	0	42.6	37	75.3	133	118	0	34	32
2015	7	18	2	13	24	0.781	-0.112	4.236	0.01	0.007	0	42.6	37.4	71	133	118	0	34	31
2015	7	18	2	23	24	0.794	-0.079	4.232	0.01	0.007	0	42.6	37	65.8	133	118	0	34	32
2015	7	18	2	33	24	0.774	-0.049	4.232	0.01	0.007	0	42.1	37.8	58.9	133	119	0	35	31
2015	7	18	2	43	24	0.807	-0.095	4.236	0.01	0.007	0	42.1	37.8	63.2	133	119	0	35	31
2015	7	18	2	53	24	0.814	-0.089	4.236	0.01	0.007	0	42.1	37.4	73.5	133	118	0	35	31
2015	7	18	3	3	24	0.784	-0.062	4.232	0.01	0.007	0	42.6	37.4	71.4	133	118	0	34	31
2015	7	18	3	13	24	0.797	-0.131	4.232	0.01	0.007	0	41.7	36.5	70.5	132	117	0	35	32
2015	7	18	3	23	24	0.817	-0.075	4.232	0.01	0.007	0	42.1	37.4	73.5	133	118	0	35	31
2015	7	18	3	33	24	0.787	-0.079	4.232	0.01	0.007	0	43.4	37.8	75.7	134	119	0	33	31
2015	7	18	3	43	24	0.82	-0.075	4.232	0.01	0.007	0	43	37.4	74.8	134	119	0	34	32
2015	7	18	3	53	24	0.814	-0.082	4.232	0.01	0.007	0	42.1	37	76.1	132	118	0	34	32
2015	7	18	4	3	24	0.82	-0.095	4.232	0.01	0.007	0	42.6	37	75.3	133	118	0	34	32
2015	7	18	4	13	24	0.801	-0.098	4.232	0.01	0.007	0	42.1	37	75.7	133	118	0	35	32
2015	7	18	4	23	24	0.801	-0.112	4.232	0.01	0.007	0	42.6	37	75.7	133	118	0	34	32
2015	7	18	4	33	24	0.86	-0.095	4.232	0.013	0.01	0	42.1	37.4	76.1	132	118	0	34	31
2015	7	18	4	43	24	0.827	-0.075	4.232	0.01	0.007	0	42.6	37.4	75.3	133	118	0	34	31
2015	7	18	4	53	24	0.794	-0.092	4.232	0.01	0.007	0	42.1	37	75.3	133	118	0	35	32
2015	7	18	5	3	24	0.853	-0.095	4.232	0.013	0.01	0	42.6	37.4	75.3	133	118	0	34	31
2015	7	18	5	13	24	0.892	-0.075	4.232	0.01	0.007	0	42.6	37.8	76.1	133	119	0	34	31
2015	7	18	5	23	24	0.863	-0.095	4.232	0.013	0.01	0	42.1	37.4	75.3	133	119	0	35	32
2015	7	18	5	33	24	0.807	-0.112	4.232	0.01	0.007	0	42.6	37.4	75.7	133	119	0	34	32
2015	7	18	5	43	24	0.823	-0.108	4.232	0.01	0.007	0	42.6	37.8	75.7	133	119	0	34	31
2015	7	18	5	53	24	0.843	-0.095	4.232	0.01	0.007	0	42.1	37.4	75.7	133	119	0	35	32
2015	7	18	6	3	24	0.807	-0.105	4.232	0.01	0.007	0	42.6	37.4	76.1	133	118	0	34	31
2015	7	18	6	13	24	0.853	-0.092	4.232	0.01	0.007	0	42.1	36.5	75.7	133	118	0	35	33
2015	7	18	6	23	24	0.827	-0.079	4.232	0.013	0.01	0	42.6	37	76.1	133	118	0	34	32
2015	7	18	6	33	24	0.791	-0.082	4.232	0.016	0.013	0	42.1	37	75.7	132	118	0	34	32
2015	7	18	6	43	24	0.843	-0.112	4.232	0.013	0.01	0	42.1	36.5	75.3	132	117	0	34	32
2015	7	18	6	53	24	0.843	-0.082	4.232	0.01	0.007	0	42.1	37	75.3	132	118	0	34	32
2015	7	18	7	3	24	0.823	-0.125	4.232	0.013	0.01	0	42.1	36.5	75.3	132	117	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	
2015	7	18	7	13	24	0.774	-0.089	4.232	0.01	0.007		0	42.1	36.5	74.4	132	117	0	34	32
2015	7	18	7	23	24	0.873	-0.095	4.229	0.01	0.007		0	42.1	36.5	75.7	132	117	0	34	32
2015	7	18	7	33	24	0.82	-0.102	4.229	0.013	0.01		0	42.1	37	76.1	132	117	0	34	31
2015	7	18	7	43	24	0.794	-0.095	4.229	0.016	0.013		0	42.1	37.4	74.4	132	118	0	34	31
2015	7	18	7	53	24	0.814	-0.095	4.229	0.01	0.007		0	41.7	37.4	75.7	132	118	0	35	31
2015	7	18	8	3	24	0.84	-0.095	4.229	0.01	0.007		0	42.1	36.5	76.1	132	117	0	34	32
2015	7	18	8	13	24	0.84	-0.079	4.229	0.01	0.007		0	41.7	36.5	75.3	131	117	0	34	32
2015	7	18	8	23	24	0.827	-0.102	4.229	0.01	0.007		0	41.7	36.5	76.1	132	117	0	35	32
2015	7	18	8	33	24	0.807	-0.128	4.229	0.01	0.007		0	42.1	37	76.5	132	118	0	34	32
2015	7	18	8	43	24	0.801	-0.062	4.229	0.01	0.007		0	42.1	37	76.1	132	118	0	34	32
2015	7	18	8	53	24	0.81	-0.095	4.229	0.01	0.007		0	42.1	37	76.5	132	118	0	34	32
2015	7	18	9	3	24	0.814	-0.052	4.229	0.01	0.007		0	41.7	36.5	74.8	132	117	0	35	32
2015	7	18	9	13	24	0.81	-0.108	4.229	0.01	0.007		0	42.1	37.4	73.1	132	118	0	34	31
2015	7	18	9	23	24	0.837	-0.062	4.229	0.01	0.007		0	42.1	37.4	72.2	133	119	0	35	32
2015	7	18	9	33	24	0.827	-0.108	4.229	0.01	0.007		0	42.6	37.8	75.7	133	119	0	34	31
2015	7	18	9	43	24	0.794	-0.095	4.229	0.013	0.01		0	42.6	37.8	76.1	133	119	0	34	31
2015	7	18	9	53	24	0.823	-0.108	4.229	0.01	0.007		0	42.6	37.4	75.3	133	119	0	34	32
2015	7	18	10	3	24	0.781	-0.092	4.229	0.01	0.007		0	42.6	37	72.2	133	118	0	34	32
2015	7	18	10	13	24	0.823	-0.105	4.229	0.016	0.013		0	42.1	37	71	132	118	0	34	32
2015	7	18	10	23	24	0.797	-0.118	4.229	0.01	0.007		0	42.1	37.4	71.4	132	118	0	34	31
2015	7	18	10	33	24	0.794	-0.115	4.229	0.01	0.007		0	42.1	37	64.9	132	118	0	34	32
2015	7	18	10	43	24	0.817	-0.089	4.229	0.01	0.007		0	42.1	37	69.7	132	118	0	34	32
2015	7	18	10	53	24	0.804	-0.092	4.229	0.01	0.007		0	42.1	37.4	63.2	132	118	0	34	31
2015	7	18	11	3	24	0.801	-0.121	4.229	0.01	0.007		0	41.7	36.5	59.8	131	117	0	34	32
2015	7	18	11	13	24	0.778	-0.069	4.229	0.01	0.007		0	41.7	36.5	73.5	131	117	0	34	32
2015	7	18	11	23	24	0.774	-0.089	4.229	0.01	0.007		0	41.3	36.1	74.4	130	116	0	34	32
2015	7	18	11	33	24	0.791	-0.082	4.229	0.01	0.007		0	42.1	36.1	72.2	131	116	0	33	32
2015	7	18	11	43	24	0.794	-0.102	4.226	0.01	0.007		0	41.7	36.5	59.3	131	117	0	34	32
2015	7	18	11	53	24	0.797	-0.102	4.226	0.01	0.007		0	41.7	37	59.8	131	117	0	34	31
2015	7	18	12	3	24	0.823	-0.121	4.226	0.016	0.013		0	41.3	36.1	58.5	130	116	0	34	32
2015	7	18	12	13	24	0.823	-0.112	4.226	0.01	0.007		0	41.3	35.7	63.6	130	115	0	34	32
2015	7	18	12	23	24	0.817	-0.062	4.226	0.01	0.007		0	42.1	36.5	57.2	131	116	0	33	31
2015	7	18	12	33	24	0.797	-0.075	4.226	0.01	0.007		0	41.7	36.1	57.2	131	116	0	34	32
2015	7	18	12	43	24	0.771	-0.085	4.226	0.01	0.007		0	41.7	36.1	57.6	131	116	0	34	32
2015	7	18	12	53	24	0.784	-0.079	4.222	0.013	0.01		0	42.1	37	52.5	132	118	0	34	32
2015	7	18	13	3	24	0.768	-0.098	4.222	0.01	0.007		0	43	37.8	52.9	134	119	0	34	31
2015	7	18	13	13	24	0.817	-0.112	4.219	0.01	0.007		0	42.6	38.3	50.7	134	120	0	35	31
2015	7	18	13	23	24	0.784	-0.095	4.219	0.01	0.007		0	42.6	37	53.8	133	118	0	34	32
2015	7	18	13	33	24	0.751	-0.066	4.216	0.01	0.007		0	44.3	39.1	49.9	137	122	0	34	31
2015	7	18	13	43	24	0.748	-0.039	4.216	0.01	0.007		0	47.7	42.1	51.6	145	130	0	34	32
2015	7	18	13	53	24	0.801	-0.095	4.216	0.01	0.007		0	47.3	41.7	49.5	144	129	0	34	32
2015	7	18	14	3	24	0.755	-0.082	4.216	0.01	0.007		0	46.9	41.7	51.6	143	128	0	34	31
2015	7	18	14	13	24	0.748	-0.112	4.213	0.01	0.007		0	46.4	40.9	52.5	142	127	0	34	32
2015	7	18	14	23	24	0.732	-0.082	4.213	0.016	0.013		0	46.4	40.9	50.3	142	127	0	34	32
2015	7	18	14	33	24	0.764	-0.082	4.213	0.013	0.01		0	46.9	41.3	49.9	143	128	0	34	32
2015	7	18	14	43	24	0.751	-0.079	4.213	0.01	0.007		0	46.4	41.3	49.5	142	128	0	34	32
2015	7	18	14	53	24	0.738	-0.085	4.216	0.013	0.01		0	45.2	40.4	52.5	140	126	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	18	15	3	24	0.741	-0.089	4.206	0.01	0.007	0	45.2	39.6	50.3	139	124	0	34	32
2015	7	18	15	13	24	0.755	-0.085	4.213	0.013	0.01	0	45.2	40	50.3	138	124	0	33	31
2015	7	18	15	23	24	0.758	-0.079	4.213	0.01	0.007	0	44.7	39.1	51.2	138	123	0	34	32
2015	7	18	15	33	24	0.787	-0.108	4.213	0.01	0.007	0	43.9	37.8	49.9	136	121	0	34	33
2015	7	18	15	43	24	0.738	-0.092	4.209	0.01	0.007	0	43.9	38.7	49.5	136	122	0	34	32
2015	7	18	15	53	24	0.751	-0.082	4.209	0.01	0.007	0	44.3	39.6	49	138	123	0	35	31
2015	7	18	16	3	24	0.722	-0.085	4.213	0.01	0.007	0	44.7	40	51.2	139	124	0	35	31
2015	7	18	16	13	24	0.751	-0.085	4.213	0.01	0.007	0	45.2	40	50.3	139	124	0	34	31
2015	7	18	16	23	24	0.732	-0.072	4.209	0.01	0.007	0	44.7	39.6	50.3	139	124	0	35	32
2015	7	18	16	33	24	0.778	-0.108	4.209	0.01	0.007	0	45.2	40	48.6	139	124	0	34	31
2015	7	18	16	43	24	0.778	-0.098	4.213	0.01	0.007	0	44.3	38.7	51.2	137	122	0	34	32
2015	7	18	16	53	24	0.745	-0.092	4.213	0.01	0.007	0	44.3	39.1	51.6	137	123	0	34	32
2015	7	18	17	3	24	0.758	-0.089	4.213	0.01	0.007	0	44.3	39.1	51.6	137	122	0	34	31
2015	7	18	17	13	24	0.728	-0.102	4.213	0.01	0.007	0	43.9	38.7	52	136	122	0	34	32
2015	7	18	17	23	24	0.719	-0.069	4.209	0.01	0.007	0	44.3	39.1	52	137	122	0	34	31
2015	7	18	17	33	24	0.771	-0.082	4.213	0.01	0.007	0	43.9	38.7	50.7	136	121	0	34	31
2015	7	18	17	43	24	0.784	-0.072	4.213	0.01	0.007	0	43.4	38.3	52	135	121	0	34	32
2015	7	18	17	53	24	0.801	-0.066	4.216	0.01	0.007	0	43.4	37.8	48.2	135	120	0	34	32
2015	7	18	18	3	24	0.787	-0.108	4.213	0.01	0.007	0	43	38.3	52.9	134	120	0	34	31
2015	7	18	18	13	24	0.764	-0.079	4.216	0.01	0.007	0	42.6	37.8	52	134	120	0	35	32
2015	7	18	18	23	24	0.771	-0.092	4.216	0.01	0.007	0	43	38.3	52.9	134	120	0	34	31
2015	7	18	18	33	24	0.771	-0.098	4.213	0.01	0.007	0	43.9	38.7	51.6	136	121	0	34	31
2015	7	18	18	43	24	0.764	-0.128	4.216	0.01	0.007	0	43.9	38.3	50.3	136	121	0	34	32
2015	7	18	18	53	24	0.781	-0.095	4.216	0.01	0.007	0	43.4	38.3	52.5	135	121	0	34	32
2015	7	18	19	3	24	0.784	-0.085	4.219	0.013	0.01	0	43.4	38.3	52.9	135	121	0	34	32
2015	7	18	19	13	24	0.807	-0.079	4.219	0.01	0.007	0	43	37.8	52.5	134	120	0	34	32
2015	7	18	19	23	24	0.814	-0.089	4.219	0.01	0.007	0	43	37.4	54.2	134	119	0	34	32
2015	7	18	19	33	24	0.774	-0.115	4.219	0.013	0.01	0	43	37.4	49.5	134	119	0	34	32
2015	7	18	19	43	24	0.787	-0.079	4.219	0.01	0.007	0	43	37.4	52.9	134	119	0	34	32
2015	7	18	19	53	24	0.791	-0.082	4.222	0.013	0.01	0	43.4	37.8	51.6	135	120	0	34	32
2015	7	18	20	3	24	0.771	-0.098	4.219	0.01	0.007	0	43	37.4	50.7	134	119	0	34	32
2015	7	18	20	13	24	0.801	-0.079	4.222	0.01	0.007	0	43	37.4	55.9	135	119	0	35	32
2015	7	18	20	23	24	0.787	-0.112	4.226	0.01	0.007	0	42.6	37.8	54.2	134	119	0	35	31
2015	7	18	20	33	24	0.748	-0.102	4.222	0.013	0.01	0	42.6	37	58	134	119	0	35	33
2015	7	18	20	43	24	0.781	-0.085	4.222	0.016	0.013	0	43.9	37.8	54.2	135	119	0	33	31
2015	7	18	20	53	24	0.791	-0.105	4.222	0.016	0.016	0	43.4	37.4	55	135	119	0	34	32
2015	7	18	21	3	24	0.801	-0.105	4.226	0.01	0.007	0	43	37.8	53.3	135	119	0	35	31
2015	7	18	21	13	24	0.797	-0.095	4.226	0.01	0.007	0	43.4	37.4	55	135	119	0	34	32
2015	7	18	21	23	24	0.774	-0.112	4.226	0.013	0.01	0	43	37.8	55.5	134	119	0	34	31
2015	7	18	21	33	24	0.797	-0.085	4.229	0.01	0.007	0	43	37	59.8	134	118	0	34	32
2015	7	18	21	43	24	0.794	-0.125	4.229	0.013	0.01	0	43	37.4	67.1	134	118	0	34	31
2015	7	18	21	53	24	0.797	-0.092	4.229	0.01	0.007	0	42.6	36.5	71	133	117	0	34	32
2015	7	18	22	3	24	0.774	-0.079	4.229	0.01	0.007	0	42.6	36.5	69.7	133	117	0	34	32
2015	7	18	22	13	24	0.846	-0.089	4.229	0.01	0.007	0	42.6	36.5	76.1	133	117	0	34	32
2015	7	18	22	23	24	0.833	-0.105	4.229	0.01	0.007	0	42.6	37.4	76.5	133	118	0	34	31
2015	7	18	22	33	24	0.817	-0.105	4.229	0.01	0.007	0	42.6	36.5	77	133	117	0	34	32
2015	7	18	22	43	24	0.837	-0.085	4.229	0.01	0.007	0	42.1	36.1	77	132	116	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	18	22	53	24	0.823	-0.089	4.229	0.01	0.007	0	42.1	37	76.5	132	117	0	34	31
2015	7	18	23	3	24	0.817	-0.079	4.232	0.01	0.007	0	41.7	36.5	77	132	117	0	35	32
2015	7	18	23	13	24	0.853	-0.118	4.232	0.01	0.007	0	42.1	37	76.5	132	117	0	34	31
2015	7	18	23	23	24	0.86	-0.082	4.232	0.01	0.007	0	42.1	36.5	76.1	132	116	0	34	31
2015	7	18	23	33	24	0.817	-0.089	4.232	0.01	0.007	0	42.1	36.5	75.7	132	117	0	34	32
2015	7	18	23	43	24	0.784	-0.082	4.232	0.01	0.007	0	42.1	36.5	75.7	132	117	0	34	32
2015	7	18	23	53	24	0.84	-0.095	4.232	0.013	0.01	0	42.1	36.5	76.1	132	116	0	34	31
2015	7	19	0	3	24	0.869	-0.069	4.232	0.01	0.007	0	42.1	36.5	76.5	132	117	0	34	32
2015	7	19	0	13	24	0.856	-0.098	4.232	0.01	0.007	0	42.6	37	76.1	133	117	0	34	31
2015	7	19	0	23	24	0.797	-0.102	4.236	0.01	0.007	0	42.6	36.5	76.1	133	117	0	34	32
2015	7	19	0	33	24	0.82	-0.085	4.236	0.01	0.007	0	42.6	37	74	133	117	0	34	31
2015	7	19	0	43	24	0.827	-0.108	4.236	0.01	0.007	0	42.6	37	75.3	133	117	0	34	31
2015	7	19	0	53	24	0.83	-0.095	4.236	0.01	0.007	0	42.1	36.5	75.3	132	116	0	34	31
2015	7	19	1	3	24	0.827	-0.115	4.236	0.01	0.007	0	42.1	36.5	76.1	132	116	0	34	31
2015	7	19	1	13	24	0.863	-0.125	4.236	0.013	0.01	0	41.7	35.7	74.8	131	115	0	34	32
2015	7	19	1	23	24	0.856	-0.082	4.236	0.01	0.007	0	41.3	36.1	74.8	131	116	0	35	32
2015	7	19	1	33	24	0.86	-0.118	4.236	0.01	0.007	0	41.7	36.1	74.8	131	116	0	34	32
2015	7	19	1	43	24	0.82	-0.085	4.236	0.01	0.007	0	42.1	36.5	74	132	116	0	34	31
2015	7	19	1	53	24	0.85	-0.066	4.236	0.01	0.007	0	42.1	36.1	75.3	132	116	0	34	32
2015	7	19	2	3	24	0.863	-0.085	4.236	0.013	0.01	0	42.1	36.5	74.4	132	116	0	34	31
2015	7	19	2	13	24	0.823	-0.089	4.236	0.01	0.007	0	42.1	36.5	74.4	132	116	0	34	31
2015	7	19	2	23	24	0.804	-0.069	4.239	0.016	0.013	0	41.7	36.5	73.5	131	116	0	34	31
2015	7	19	2	33	24	0.84	-0.095	4.239	0.013	0.01	0	41.7	36.1	74	131	115	0	34	31
2015	7	19	2	43	24	0.866	-0.108	4.239	0.01	0.007	0	41.7	36.1	74.4	132	116	0	35	32
2015	7	19	2	53	24	0.807	-0.105	4.239	0.01	0.007	0	42.1	36.5	73.5	132	116	0	34	31
2015	7	19	3	3	24	0.801	-0.066	4.239	0.01	0.007	0	42.1	36.1	72.2	132	116	0	34	32
2015	7	19	3	13	24	0.801	-0.066	4.239	0.01	0.007	0	42.1	37	72.2	132	117	0	34	31
2015	7	19	3	23	24	0.837	-0.075	4.242	0.01	0.007	0	42.1	36.5	72.7	132	116	0	34	31
2015	7	19	3	33	24	0.827	-0.089	4.242	0.013	0.01	0	42.1	36.1	72.7	132	116	0	34	32
2015	7	19	3	43	24	0.82	-0.062	4.242	0.01	0.007	0	42.6	37	73.1	133	117	0	34	31
2015	7	19	3	53	24	0.791	-0.095	4.245	0.01	0.007	0	42.6	36.5	73.5	133	117	0	34	32
2015	7	19	4	3	24	0.83	-0.112	4.245	0.01	0.007	0	41.7	37	73.5	132	117	0	35	31
2015	7	19	4	13	24	0.86	-0.095	4.249	0.013	0.01	0	42.1	37	73.5	132	117	0	34	31
2015	7	19	4	23	24	0.814	-0.085	4.249	0.01	0.007	0	42.1	36.5	72.7	133	117	0	35	32
2015	7	19	4	33	24	0.81	-0.092	4.252	0.01	0.007	0	42.6	36.5	72.7	133	117	0	34	32
2015	7	19	4	43	24	0.83	-0.102	4.252	0.01	0.007	0	41.7	36.5	73.1	132	117	0	35	32
2015	7	19	4	53	24	0.846	-0.085	4.252	0.01	0.007	0	42.6	36.5	71	133	117	0	34	32
2015	7	19	5	3	24	0.814	-0.125	4.252	0.01	0.007	0	42.6	37	74.4	133	118	0	34	32
2015	7	19	5	13	24	0.817	-0.112	4.252	0.013	0.01	0	42.6	37	74	134	118	0	35	32
2015	7	19	5	23	24	0.807	-0.062	4.255	0.01	0.007	0	42.1	37	74.4	133	118	0	35	32
2015	7	19	5	33	24	0.778	-0.098	4.255	0.01	0.007	0	43	37	74.4	134	118	0	34	32
2015	7	19	5	43	24	0.84	-0.108	4.252	0.01	0.007	0	43	37	74.4	134	118	0	34	32
2015	7	19	5	53	24	0.817	-0.072	4.255	0.01	0.007	0	43	37	74	134	118	0	34	32
2015	7	19	6	3	24	0.801	-0.121	4.255	0.01	0.007	0	42.6	37.4	74.8	134	118	0	35	31
2015	7	19	6	13	24	0.807	-0.105	4.255	0.016	0.013	0	42.1	37	75.7	133	117	0	35	31
2015	7	19	6	23	24	0.886	-0.082	4.255	0.01	0.007	0	42.6	37	75.7	133	117	0	34	31
2015	7	19	6	33	24	0.843	-0.098	4.255	0.01	0.007	0	43	37.4	74.4	134	118	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	19	6	43	24	0.791	-0.095	4.255	0.01	0.007	0	42.1	37	76.1	133	117	0	35	31
2015	7	19	6	53	24	0.82	-0.112	4.255	0.01	0.007	0	42.1	36.5	76.5	132	117	0	34	32
2015	7	19	7	3	24	0.846	-0.069	4.259	0.01	0.007	0	41.7	37	77	132	117	0	35	31
2015	7	19	7	13	24	0.81	-0.066	4.259	0.01	0.007	0	41.7	36.1	76.5	132	116	0	35	32
2015	7	19	7	23	24	0.804	-0.095	4.259	0.01	0.007	0	41.3	36.1	75.7	131	116	0	35	32
2015	7	19	7	33	24	0.84	-0.079	4.259	0.01	0.007	0	42.1	36.5	76.1	132	117	0	34	32
2015	7	19	7	43	24	0.807	-0.085	4.259	0.01	0.007	0	42.1	36.5	77	132	117	0	34	32
2015	7	19	7	53	24	0.823	-0.098	4.259	0.013	0.01	0	42.1	36.1	77.4	132	116	0	34	32
2015	7	19	8	3	24	0.83	-0.095	4.259	0.01	0.007	0	41.7	36.1	76.5	131	116	0	34	32
2015	7	19	8	13	24	0.797	-0.108	4.259	0.013	0.01	0	41.7	36.5	77	131	116	0	34	31
2015	7	19	8	23	24	0.784	-0.115	4.259	0.01	0.007	0	42.1	36.1	76.1	132	116	0	34	32
2015	7	19	8	33	24	0.823	-0.092	4.262	0.01	0.007	0	41.7	36.5	77.4	132	117	0	35	32
2015	7	19	8	43	24	0.823	-0.095	4.262	0.01	0.007	0	42.1	36.1	77	132	116	0	34	32
2015	7	19	8	53	24	0.853	-0.108	4.262	0.013	0.01	0	41.3	36.1	77	131	116	0	35	32
2015	7	19	9	3	24	0.83	-0.075	4.262	0.013	0.01	0	41.7	36.1	76.1	132	116	0	35	32
2015	7	19	9	13	24	0.81	-0.115	4.262	0.01	0.007	0	41.7	36.5	76.5	132	117	0	35	32
2015	7	19	9	23	24	0.833	-0.082	4.262	0.01	0.007	0	42.1	36.5	70.1	132	117	0	34	32
2015	7	19	9	33	24	0.843	-0.079	4.262	0.013	0.01	0	41.7	37	77	132	117	0	35	31
2015	7	19	9	43	24	0.791	-0.095	4.262	0.013	0.01	0	42.1	37	77	132	117	0	34	31
2015	7	19	9	53	24	0.82	-0.138	4.262	0.01	0.007	0	42.1	36.5	77	132	117	0	34	32
2015	7	19	10	3	24	0.843	-0.089	4.265	0.01	0.007	0	42.1	37	76.1	132	117	0	34	31
2015	7	19	10	13	24	0.807	-0.115	4.265	0.01	0.007	0	42.6	37	76.1	133	118	0	34	32
2015	7	19	10	23	24	0.823	-0.112	4.265	0.01	0.007	0	42.1	36.5	75.3	132	117	0	34	32
2015	7	19	10	33	24	0.817	-0.105	4.265	0.01	0.007	0	42.1	37.4	71.4	133	118	0	35	31
2015	7	19	10	43	24	0.846	-0.092	4.265	0.01	0.007	0	42.6	37.8	70.5	133	119	0	34	31
2015	7	19	10	53	24	0.817	-0.115	4.265	0.01	0.007	0	41.7	36.5	73.5	132	117	0	35	32
2015	7	19	11	3	24	0.873	-0.135	4.265	0.01	0.007	0	42.1	37.4	72.2	133	118	0	35	31
2015	7	19	11	13	24	0.814	-0.112	4.265	0.01	0.007	0	42.6	37	73.5	133	118	0	34	32
2015	7	19	11	23	24	0.869	-0.108	4.265	0.01	0.007	0	42.6	37.4	73.5	133	118	0	34	31
2015	7	19	11	33	24	0.791	-0.072	4.265	0.01	0.007	0	42.1	36.5	68.4	132	117	0	34	32
2015	7	19	11	43	24	0.814	-0.079	4.268	0.01	0.007	0	42.1	36.5	74	132	117	0	34	32
2015	7	19	11	53	24	0.837	-0.085	4.268	0.01	0.007	0	41.7	37	62.4	132	118	0	35	32
2015	7	19	12	3	24	0.823	-0.108	4.268	0.01	0.007	0	41.7	36.5	66.2	132	117	0	35	32
2015	7	19	12	13	24	0.846	-0.128	4.268	0.013	0.01	0	41.3	36.5	74	131	116	0	35	31
2015	7	19	12	23	24	0.797	-0.118	4.268	0.013	0.01	0	42.6	37.8	64.5	134	119	0	35	31
2015	7	19	12	33	24	0.791	-0.079	4.268	0.01	0.007	0	42.6	37	71.4	133	118	0	34	32
2015	7	19	12	43	24	0.83	-0.112	4.268	0.013	0.01	0	41.7	36.5	74.4	131	116	0	34	31
2015	7	19	12	53	24	0.81	-0.046	4.268	0.01	0.007	0	41.3	36.1	76.1	131	115	0	35	31
2015	7	19	13	3	24	0.764	-0.089	4.268	0.01	0.007	0	42.1	37	76.5	132	117	0	34	31
2015	7	19	13	13	24	0.827	-0.105	4.268	0.01	0.007	0	41.3	36.1	69.2	130	116	0	34	32
2015	7	19	13	23	24	0.82	-0.112	4.272	0.01	0.007	0	41.7	36.1	70.1	131	115	0	34	31
2015	7	19	13	33	24	0.817	-0.108	4.272	0.01	0.007	0	41.7	36.5	74.4	131	116	0	34	31
2015	7	19	13	43	24	0.83	-0.095	4.272	0.013	0.01	0	41.3	36.1	77	130	115	0	34	31
2015	7	19	13	53	24	0.817	-0.089	4.272	0.01	0.007	0	40.9	35.7	76.5	130	114	0	35	31
2015	7	19	14	3	24	0.807	-0.095	4.272	0.01	0.007	0	41.3	36.1	74	130	115	0	34	31
2015	7	19	14	13	24	0.791	-0.112	4.272	0.013	0.01	0	41.3	35.7	76.5	130	115	0	34	32
2015	7	19	14	23	24	0.823	-0.089	4.272	0.01	0.007	0	41.7	36.1	76.1	131	115	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	19	14	33	24	0.82	-0.079	4.272	0.01	0.007	0	42.1	36.5	68.4	132	117	0	34	32
2015	7	19	14	43	24	0.801	-0.095	4.272	0.01	0.007	0	42.1	36.5	73.5	132	117	0	34	32
2015	7	19	14	53	24	0.833	-0.095	4.275	0.01	0.007	0	41.7	35.7	76.5	131	115	0	34	32
2015	7	19	15	3	24	0.81	-0.085	4.275	0.01	0.007	0	41.3	36.1	70.1	131	115	0	35	31
2015	7	19	15	13	24	0.84	-0.072	4.275	0.01	0.007	0	41.3	35.7	68.8	131	115	0	35	32
2015	7	19	15	23	24	0.797	-0.095	4.275	0.01	0.007	0	41.3	35.7	71.8	130	115	0	34	32
2015	7	19	15	33	24	0.814	-0.072	4.275	0.01	0.007	0	41.7	35.7	65.8	131	115	0	34	32
2015	7	19	15	43	24	0.758	-0.112	4.275	0.013	0.01	0	41.7	35.3	64.5	131	115	0	34	33
2015	7	19	15	53	24	0.823	-0.089	4.275	0.01	0.007	0	41.3	35.7	71.8	130	115	0	34	32
2015	7	19	16	3	24	0.791	-0.082	4.275	0.013	0.01	0	41.3	35.7	57.6	130	115	0	34	32
2015	7	19	16	13	24	0.801	-0.095	4.275	0.01	0.007	0	41.3	36.1	62.4	130	115	0	34	31
2015	7	19	16	23	24	0.807	-0.098	4.275	0.01	0.007	0	41.3	35.7	62.4	130	115	0	34	32
2015	7	19	16	33	24	0.807	-0.079	4.275	0.01	0.007	0	41.7	36.1	58	131	115	0	34	31
2015	7	19	16	43	24	0.807	-0.079	4.278	0.01	0.007	0	42.1	36.1	55.5	132	116	0	34	32
2015	7	19	16	53	24	0.823	-0.089	4.278	0.01	0.007	0	42.6	36.5	52.9	133	117	0	34	32
2015	7	19	17	3	24	0.797	-0.105	4.278	0.013	0.01	0	42.6	37	56.3	133	117	0	34	31
2015	7	19	17	13	24	0.823	-0.115	4.278	0.01	0.007	0	42.1	36.1	58	132	116	0	34	32
2015	7	19	17	23	24	0.843	-0.128	4.275	0.013	0.01	0	42.1	36.1	59.3	132	116	0	34	32
2015	7	19	17	33	24	0.827	-0.102	4.278	0.013	0.01	0	41.7	36.1	56.8	131	116	0	34	32
2015	7	19	17	43	24	0.82	-0.082	4.278	0.016	0.013	0	41.7	36.5	58	132	116	0	35	31
2015	7	19	17	53	24	0.82	-0.082	4.278	0.01	0.007	0	42.1	36.5	58	132	117	0	34	32
2015	7	19	18	3	24	0.797	-0.095	4.278	0.01	0.007	0	42.1	36.5	55.9	132	116	0	34	31
2015	7	19	18	13	24	0.804	-0.079	4.278	0.01	0.007	0	41.7	36.1	64.5	131	116	0	34	32
2015	7	19	18	23	24	0.85	-0.089	4.278	0.01	0.007	0	49	43	42.6	148	131	0	34	31
2015	7	19	18	33	24	0.82	-0.079	4.281	0.01	0.007	0	46	40	46.9	141	125	0	34	32
2015	7	19	18	43	24	0.85	-0.085	4.281	0.013	0.01	0	46.4	40.9	46.4	142	126	0	34	31
2015	7	19	18	53	24	0.853	-0.095	4.281	0.013	0.01	0	48.6	42.6	42.1	147	130	0	34	31
2015	7	19	19	3	24	0.866	-0.085	4.281	0.01	0.007	0	46.9	40	42.6	142	124	0	33	31
2015	7	19	19	13	24	0.804	-0.069	4.281	0.01	0.007	0	52.9	48.2	38.3	158	143	0	35	31
2015	7	19	19	23	24	0.942	-0.069	4.285	0.01	0.007	0	48.2	43	39.1	146	131	0	34	31
2015	7	19	19	33	24	0.922	-0.066	4.285	0.01	0.007	0	48.2	42.6	42.1	145	131	0	33	32
2015	7	19	19	43	24	0.935	-0.075	4.291	0.01	0.007	0	48.2	43.4	42.6	146	132	0	34	31
2015	7	19	19	53	24	0.856	-0.079	4.285	0.013	0.01	0	50.3	43.4	40.4	151	133	0	34	32
2015	7	19	20	3	24	0.833	-0.079	4.288	0.01	0.007	0	42.6	37	65.8	133	118	0	34	32
2015	7	19	20	13	24	0.84	-0.049	4.288	0.01	0.007	0	43	37.4	70.5	134	119	0	34	32
2015	7	19	20	23	24	0.81	-0.118	4.288	0.01	0.007	0	41.3	37	71.8	130	118	0	34	32
2015	7	19	20	33	24	0.853	-0.066	4.291	0.016	0.013	0	43	37	70.5	133	117	0	33	31
2015	7	19	20	43	24	0.846	-0.105	4.291	0.01	0.007	0	42.1	37	64.9	132	117	0	34	31
2015	7	19	20	53	24	0.837	-0.075	4.298	0.01	0.007	0	43	37	61.5	133	117	0	33	31
2015	7	19	21	3	24	0.83	-0.072	4.298	0.01	0.007	0	47.7	42.1	53.3	145	130	0	34	32
2015	7	19	21	13	24	0.853	-0.066	4.301	0.01	0.007	0	49	43.9	54.6	148	133	0	34	31
2015	7	19	21	23	24	0.84	-0.079	4.301	0.01	0.007	0	48.2	42.1	70.5	146	130	0	34	32
2015	7	19	21	33	24	0.856	-0.016	4.304	0.01	0.007	0	46.4	41.7	71.4	143	128	0	35	31
2015	7	19	21	43	24	0.85	-0.092	4.304	0.01	0.007	0	46.9	41.7	58.9	143	128	0	34	31
2015	7	19	21	53	24	0.883	-0.072	4.304	0.01	0.007	0	45.6	40.4	70.1	141	126	0	35	32
2015	7	19	22	3	24	0.797	-0.033	4.308	0.01	0.007	0	45.2	40	72.7	139	124	0	34	31
2015	7	19	22	13	24	0.866	-0.095	4.308	0.01	0.007	0	44.3	38.3	73.1	137	121	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	19	22	23	24	0.85	-0.092	4.308	0.01	0.007	0	43.4	37.8	75.3	135	120	0	34	32
2015	7	19	22	33	24	0.823	-0.072	4.308	0.01	0.007	0	43	37	76.1	134	118	0	34	32
2015	7	19	22	43	24	0.883	-0.095	4.311	0.01	0.007	0	42.1	37	77	133	117	0	35	31
2015	7	19	22	53	24	0.817	-0.069	4.311	0.01	0.007	0	42.6	37	76.1	132	117	0	33	31
2015	7	19	23	3	24	0.823	-0.082	4.311	0.013	0.01	0	42.1	36.5	77	132	116	0	34	31
2015	7	19	23	13	24	0.794	-0.062	4.311	0.013	0.01	0	42.1	36.5	75.7	132	116	0	34	31
2015	7	19	23	23	24	0.84	-0.095	4.311	0.01	0.007	0	41.7	36.1	72.7	131	116	0	34	32
2015	7	19	23	33	24	0.814	-0.095	4.311	0.01	0.007	0	41.7	36.5	65.4	131	116	0	34	31
2015	7	19	23	43	24	0.82	-0.066	4.311	0.01	0.007	0	41.7	36.5	74	131	116	0	34	31
2015	7	19	23	53	24	0.797	-0.079	4.311	0.01	0.007	0	41.7	36.1	74	131	116	0	34	32
2015	7	20	0	3	24	0.82	-0.079	4.311	0.01	0.007	0	41.7	37	61.9	132	117	0	35	31
2015	7	20	0	13	24	0.833	-0.102	4.314	0.01	0.007	0	42.1	36.1	76.1	132	116	0	34	32
2015	7	20	0	23	24	0.843	-0.085	4.314	0.01	0.007	0	41.7	36.5	75.7	132	117	0	35	32
2015	7	20	0	33	24	0.853	-0.066	4.314	0.01	0.007	0	41.7	36.5	58	132	117	0	35	32
2015	7	20	0	43	24	0.814	-0.066	4.314	0.01	0.007	0	42.6	37.4	58.5	133	118	0	34	31
2015	7	20	0	53	24	0.83	-0.066	4.314	0.01	0.007	0	43	37.8	61.5	135	120	0	35	32
2015	7	20	1	3	24	0.869	-0.095	4.321	0.016	0.013	0	47.3	41.7	47.3	144	129	0	34	32
2015	7	20	1	13	24	0.863	-0.016	4.324	0.01	0.007	0	49.9	44.3	46	150	135	0	34	32
2015	7	20	1	23	24	0.853	-0.059	4.341	0.01	0.007	0	51.2	45.6	43	154	138	0	35	32
2015	7	20	1	33	24	0.863	-0.049	4.344	0.01	0.007	0	50.7	45.2	58.9	152	137	0	34	32
2015	7	20	1	43	24	0.902	-0.052	4.347	0.01	0.007	0	49.9	44.3	55	150	135	0	34	32
2015	7	20	1	53	24	0.843	-0.046	4.35	0.01	0.007	0	49	43.9	50.7	148	133	0	34	31
2015	7	20	2	3	24	0.906	-0.03	4.35	0.01	0.007	0	47.7	42.1	68.8	144	129	0	33	31
2015	7	20	2	13	24	0.83	-0.016	4.354	0.016	0.013	0	46	40.4	71.4	142	126	0	35	32
2015	7	20	2	23	24	0.837	-0.043	4.354	0.01	0.007	0	44.7	39.6	73.1	139	124	0	35	32
2015	7	20	2	33	24	0.892	-0.043	4.357	0.01	0.007	0	43.9	38.3	73.1	136	121	0	34	32
2015	7	20	2	43	24	0.84	-0.066	4.357	0.01	0.007	0	43	37.4	74	134	119	0	34	32
2015	7	20	2	53	24	0.863	-0.079	4.36	0.01	0.007	0	42.6	37	74	133	117	0	34	31
2015	7	20	3	3	24	0.889	-0.066	4.36	0.01	0.007	0	41.7	36.5	73.1	131	116	0	34	31
2015	7	20	3	13	24	0.896	-0.052	4.367	0.01	0.007	0	41.7	35.7	71.8	131	115	0	34	32
2015	7	20	3	23	24	0.846	-0.056	4.373	0.01	0.007	0	41.3	35.7	72.7	130	114	0	34	31
2015	7	20	3	33	24	0.876	-0.095	4.377	0.01	0.007	0	40.9	35.7	73.5	129	114	0	34	31
2015	7	20	3	43	24	0.846	-0.079	4.377	0.013	0.01	0	40.9	35.3	74.4	129	114	0	34	32
2015	7	20	3	53	24	0.843	-0.102	4.38	0.01	0.007	0	40.9	34.8	75.7	129	113	0	34	32
2015	7	20	4	3	24	0.833	-0.095	4.383	0.013	0.01	0	40.4	34.8	76.1	129	113	0	35	32
2015	7	20	4	13	24	0.83	-0.072	4.383	0.01	0.007	0	40.4	34.8	75.7	128	113	0	34	32
2015	7	20	4	23	24	0.866	-0.115	4.386	0.01	0.007	0	40.9	35.7	76.5	129	114	0	34	31
2015	7	20	4	33	24	0.801	-0.052	4.386	0.01	0.007	0	40.9	35.3	72.7	129	114	0	34	32
2015	7	20	4	43	24	0.83	-0.112	4.386	0.013	0.01	0	40.9	35.7	74.8	130	114	0	35	31
2015	7	20	4	53	24	0.817	-0.112	4.386	0.013	0.01	0	41.3	35.7	70.1	130	114	0	34	31
2015	7	20	5	3	24	0.846	-0.125	4.39	0.01	0.007	0	41.3	36.1	74	130	115	0	34	31
2015	7	20	5	13	24	0.846	-0.082	4.39	0.01	0.007	0	41.3	36.1	74.8	130	115	0	34	31
2015	7	20	5	23	24	0.833	-0.082	4.393	0.01	0.007	0	41.7	36.1	75.3	131	116	0	34	32
2015	7	20	5	33	24	0.833	-0.098	4.393	0.013	0.01	0	41.7	36.1	74.4	131	116	0	34	32
2015	7	20	5	43	24	0.869	-0.112	4.393	0.01	0.007	0	41.3	36.5	74	131	116	0	35	31
2015	7	20	5	53	24	0.833	-0.089	4.393	0.01	0.007	0	42.1	36.5	71	132	117	0	34	32
2015	7	20	6	3	24	0.823	-0.082	4.396	0.01	0.007	0	42.1	36.5	68.8	132	116	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	20	6	13	24	0.846	-0.095	4.4	0.01	0.007	0	42.6	37	71.8	132	117	0	33	31
2015	7	20	6	23	24	0.807	-0.095	4.4	0.01	0.007	0	41.7	36.1	72.7	132	117	0	35	33
2015	7	20	6	33	24	0.866	-0.105	4.403	0.01	0.007	0	42.1	36.1	66.7	132	116	0	34	32
2015	7	20	6	43	24	0.886	-0.141	4.409	0.01	0.007	0	42.1	36.5	72.7	132	117	0	34	32
2015	7	20	6	53	24	0.853	-0.085	4.413	0.013	0.01	0	41.7	36.1	72.2	131	115	0	34	31
2015	7	20	7	3	24	0.853	-0.085	4.416	0.01	0.007	0	41.7	36.5	73.5	131	116	0	34	31
2015	7	20	7	13	24	0.843	-0.125	4.416	0.01	0.007	0	41.7	36.1	74.4	131	116	0	34	32
2015	7	20	7	23	24	0.879	-0.066	4.419	0.01	0.007	0	41.7	36.1	76.1	131	116	0	34	32
2015	7	20	7	33	24	0.846	-0.102	4.419	0.01	0.007	0	41.7	36.5	71.8	131	116	0	34	31
2015	7	20	7	43	24	0.807	-0.082	4.423	0.01	0.007	0	42.1	36.1	68.8	132	116	0	34	32
2015	7	20	7	53	24	0.817	-0.095	4.423	0.013	0.01	0	41.7	36.1	67.9	131	116	0	34	32
2015	7	20	8	3	24	0.827	-0.118	4.423	0.01	0.007	0	41.7	36.1	66.2	131	116	0	34	32
2015	7	20	8	13	24	0.827	-0.079	4.426	0.01	0.007	0	41.7	36.5	68.4	131	116	0	34	31
2015	7	20	8	23	24	0.876	-0.075	4.426	0.01	0.007	0	42.1	36.5	61.5	132	117	0	34	32
2015	7	20	8	33	24	0.856	-0.072	4.426	0.013	0.01	0	42.6	36.5	65.4	133	118	0	34	33
2015	7	20	8	43	24	0.794	-0.079	4.429	0.01	0.007	0	43.4	37	67.1	135	118	0	34	32
2015	7	20	8	53	24	0.83	-0.098	4.429	0.01	0.007	0	43	36.5	60.6	134	117	0	34	32
2015	7	20	9	3	24	0.817	-0.108	4.432	0.013	0.01	0	46	39.6	59.3	141	124	0	34	32
2015	7	20	9	13	24	0.906	-0.066	4.436	0.01	0.007	0	46.4	40.4	68.8	142	126	0	34	32
2015	7	20	9	23	24	0.909	-0.102	4.439	0.01	0.007	0	45.6	40	70.5	140	124	0	34	31
2015	7	20	9	33	24	0.906	-0.082	4.449	0.01	0.007	0	44.3	38.3	71.4	137	121	0	34	32
2015	7	20	9	43	24	0.869	-0.033	4.452	0.01	0.007	0	43.4	37.4	73.5	135	119	0	34	32
2015	7	20	9	53	24	0.889	-0.095	4.455	0.01	0.007	0	43	37	59.8	135	118	0	35	32
2015	7	20	10	3	24	0.873	-0.082	4.455	0.01	0.007	0	44.3	38.3	59.3	137	121	0	34	32
2015	7	20	10	13	24	0.883	-0.056	4.459	0.01	0.007	0	43.9	38.3	66.2	137	121	0	35	32
2015	7	20	10	23	24	0.899	-0.072	4.462	0.01	0.007	0	43.4	37	73.1	135	119	0	34	33
2015	7	20	10	33	24	0.909	-0.085	4.462	0.01	0.007	0	42.6	37	75.7	133	117	0	34	31
2015	7	20	10	43	24	0.879	-0.092	4.465	0.01	0.007	0	42.1	36.5	76.1	132	116	0	34	31
2015	7	20	10	53	24	0.843	-0.069	4.465	0.01	0.007	0	40.9	35.3	77	130	114	0	35	32
2015	7	20	11	3	24	0.906	-0.062	4.465	0.01	0.007	0	40.9	34.8	77	129	112	0	34	31
2015	7	20	11	13	24	0.902	-0.062	4.469	0.01	0.007	0	40	34.8	76.5	128	112	0	35	31
2015	7	20	11	23	24	0.883	-0.066	4.469	0.01	0.007	0	40	34.4	77	128	111	0	35	31
2015	7	20	11	33	24	0.853	-0.059	4.472	0.01	0.007	0	39.6	34	75.7	127	111	0	35	32
2015	7	20	11	43	24	0.889	-0.062	4.472	0.01	0.007	0	40.4	34.4	76.5	128	112	0	34	32
2015	7	20	11	53	24	0.869	-0.092	4.472	0.013	0.01	0	40.4	34.8	76.1	128	112	0	34	31
2015	7	20	12	3	24	0.866	-0.082	4.475	0.01	0.007	0	40	34.8	74.8	128	112	0	35	31
2015	7	20	12	13	24	0.863	-0.079	4.475	0.01	0.007	0	40.9	34.8	74.4	129	113	0	34	32
2015	7	20	12	23	24	0.85	-0.085	4.478	0.01	0.007	0	40.9	34.8	74.4	129	113	0	34	32
2015	7	20	12	33	24	0.886	-0.108	4.482	0.013	0.01	0	40.4	34.4	73.1	128	112	0	34	32
2015	7	20	12	43	24	0.82	-0.128	4.485	0.01	0.007	0	40.4	34.4	73.5	128	112	0	34	32
2015	7	20	12	53	24	0.869	-0.095	4.491	0.013	0.01	0	40.4	34.8	74	128	112	0	34	31
2015	7	20	13	3	24	0.85	-0.075	4.495	0.01	0.007	0	40	34.4	74.4	127	112	0	34	32
2015	7	20	13	13	24	0.879	-0.098	4.495	0.01	0.007	0	40	34	75.7	127	111	0	34	32
2015	7	20	13	23	24	0.873	-0.072	4.498	0.01	0.007	0	40	34.8	75.7	128	112	0	35	31
2015	7	20	13	33	24	0.919	-0.062	4.498	0.01	0.007	0	40	34.8	75.7	128	112	0	35	31
2015	7	20	13	43	24	0.866	-0.069	4.501	0.01	0.007	0	40	34	76.5	127	111	0	34	32
2015	7	20	13	53	24	0.823	-0.095	4.501	0.01	0.007	0	39.6	34	77.4	127	111	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	20	14	3	24	0.863	-0.062	4.501	0.01	0.007	0	40	34.4	76.5	127	111	0	34	31
2015	7	20	14	13	24	0.82	-0.092	4.505	0.01	0.007	0	40.4	34	75.3	128	111	0	34	32
2015	7	20	14	23	24	0.873	-0.089	4.505	0.01	0.007	0	40.4	34	74.4	128	111	0	34	32
2015	7	20	14	33	24	0.853	-0.085	4.505	0.01	0.007	0	40	34	76.1	127	111	0	34	32
2015	7	20	14	43	24	0.86	-0.075	4.505	0.01	0.007	0	40.4	34.8	77.4	128	112	0	34	31
2015	7	20	14	53	24	0.84	-0.098	4.508	0.013	0.01	0	40.4	34.4	76.5	128	112	0	34	32
2015	7	20	15	3	24	0.843	-0.102	4.505	0.01	0.007	0	40	34.4	76.1	128	111	0	35	31
2015	7	20	15	13	24	0.817	-0.059	4.508	0.01	0.007	0	40.4	34.8	77	128	112	0	34	31
2015	7	20	15	23	24	0.866	-0.085	4.508	0.01	0.007	0	40	34.4	77	128	112	0	35	32
2015	7	20	15	33	24	0.85	-0.052	4.508	0.01	0.007	0	40.9	34.8	76.5	128	112	0	33	31
2015	7	20	15	43	24	0.837	-0.079	4.508	0.013	0.01	0	40.4	34.8	75.7	128	112	0	34	31
2015	7	20	15	53	24	0.833	-0.105	4.511	0.01	0.007	0	40	34	76.5	127	111	0	34	32
2015	7	20	16	3	24	0.909	-0.075	4.511	0.01	0.007	0	40	34	76.5	127	111	0	34	32
2015	7	20	16	13	24	0.846	-0.066	4.511	0.013	0.01	0	40	34.4	76.1	127	111	0	34	31
2015	7	20	16	23	24	0.846	-0.112	4.511	0.01	0.007	0	40	34	75.7	127	111	0	34	32
2015	7	20	16	33	24	0.84	-0.098	4.511	0.01	0.007	0	40	34.4	76.1	127	111	0	34	31
2015	7	20	16	43	24	0.853	-0.098	4.514	0.01	0.007	0	40	34.8	62.8	127	112	0	34	31
2015	7	20	16	53	24	0.886	-0.056	4.514	0.01	0.007	0	40	34.4	73.5	127	111	0	34	31
2015	7	20	17	3	24	0.846	-0.115	4.514	0.01	0.007	0	40.4	34.4	65.4	128	111	0	34	31
2015	7	20	17	13	24	0.866	-0.112	4.514	0.01	0.007	0	40.9	35.7	64.9	129	114	0	34	31
2015	7	20	17	23	24	0.873	-0.072	4.514	0.01	0.007	0	40	34	73.5	126	110	0	33	31
2015	7	20	17	33	24	0.853	-0.079	4.518	0.01	0.007	0	39.6	33.5	74.8	126	109	0	34	31
2015	7	20	17	43	24	0.876	-0.102	4.518	0.01	0.007	0	39.6	34	74.8	126	110	0	34	31
2015	7	20	17	53	24	0.919	-0.102	4.518	0.01	0.007	0	39.6	34	74.4	126	110	0	34	31
2015	7	20	18	3	24	0.883	-0.092	4.518	0.01	0.007	0	39.1	33.5	72.7	125	109	0	34	31
2015	7	20	18	13	24	0.886	-0.079	4.518	0.01	0.007	0	39.6	33.1	74.4	125	109	0	33	32
2015	7	20	18	23	24	0.856	-0.089	4.518	0.01	0.007	0	39.1	33.5	74	125	109	0	34	31
2015	7	20	18	33	24	0.863	-0.089	4.518	0.01	0.007	0	39.1	33.1	74	125	108	0	34	31
2015	7	20	18	43	24	0.886	-0.085	4.521	0.01	0.007	0	38.7	33.1	74	125	108	0	35	31
2015	7	20	18	53	24	0.873	-0.115	4.521	0.01	0.007	0	39.6	33.5	74	126	109	0	34	31
2015	7	20	19	3	24	0.902	-0.075	4.521	0.01	0.007	0	39.6	33.1	74.4	126	109	0	34	32
2015	7	20	19	13	24	0.886	-0.075	4.521	0.01	0.007	0	39.6	33.1	73.1	126	109	0	34	32
2015	7	20	19	23	24	0.86	-0.079	4.521	0.01	0.007	0	39.6	34	73.5	126	110	0	34	31
2015	7	20	19	33	24	0.823	-0.069	4.524	0.016	0.013	0	39.6	33.1	73.5	126	109	0	34	32
2015	7	20	19	43	24	0.833	-0.125	4.524	0.01	0.007	0	39.1	33.1	72.2	125	109	0	34	32
2015	7	20	19	53	24	0.906	-0.092	4.528	0.013	0.01	0	39.6	33.1	72.7	126	109	0	34	32
2015	7	20	20	3	24	0.869	-0.066	4.528	0.01	0.007	0	39.1	33.5	58	126	109	0	35	31
2015	7	20	20	13	24	0.876	-0.118	4.531	0.01	0.007	0	39.6	33.5	72.7	126	109	0	34	31
2015	7	20	20	23	24	0.883	-0.095	4.531	0.01	0.007	0	39.6	34	73.5	126	110	0	34	31
2015	7	20	20	33	24	0.853	-0.079	4.534	0.01	0.007	0	39.1	34	72.7	126	110	0	35	31
2015	7	20	20	43	24	0.853	-0.092	4.534	0.01	0.007	0	40	33.5	73.1	127	110	0	34	32
2015	7	20	20	53	24	0.886	-0.085	4.534	0.01	0.007	0	39.6	34	73.5	126	110	0	34	31
2015	7	20	21	3	24	0.902	-0.075	4.534	0.01	0.007	0	39.6	33.5	74	126	109	0	34	31
2015	7	20	21	13	24	0.869	-0.095	4.534	0.01	0.007	0	39.1	33.5	74	125	109	0	34	31
2015	7	20	21	23	24	0.83	-0.049	4.537	0.013	0.01	0	39.1	32.7	74.8	125	108	0	34	32
2015	7	20	21	33	24	0.873	-0.066	4.537	0.013	0.01	0	38.7	33.1	75.3	125	108	0	35	31
2015	7	20	21	43	24	0.853	-0.089	4.537	0.01	0.007	0	39.1	33.5	74	125	109	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	20	21	53	24	0.896	-0.072	4.537	0.01	0.007	0	38.3	32.7	74.8	124	108	0	35	32
2015	7	20	22	3	24	0.85	-0.085	4.537	0.013	0.01	0	38.7	32.3	74.4	124	107	0	34	32
2015	7	20	22	13	24	0.863	-0.089	4.537	0.01	0.007	0	38.7	33.1	74.4	124	108	0	34	31
2015	7	20	22	23	24	0.883	-0.105	4.537	0.01	0.007	0	39.1	32.3	74.4	124	107	0	33	32
2015	7	20	22	33	24	0.853	-0.112	4.537	0.01	0.007	0	38.7	33.1	74	124	108	0	34	31
2015	7	20	22	43	24	0.876	-0.108	4.537	0.01	0.007	0	38.7	33.1	75.3	124	108	0	34	31
2015	7	20	22	53	24	0.902	-0.085	4.537	0.01	0.007	0	39.1	33.1	75.3	125	108	0	34	31
2015	7	20	23	3	24	0.909	-0.102	4.534	0.01	0.007	0	39.1	32.7	74	125	108	0	34	32
2015	7	20	23	13	24	0.892	-0.092	4.537	0.016	0.013	0	38.7	32.7	74.8	124	108	0	34	32
2015	7	20	23	23	24	0.876	-0.092	4.537	0.01	0.007	0	39.1	32.7	74.8	124	107	0	33	31
2015	7	20	23	33	24	0.869	-0.075	4.534	0.01	0.007	0	38.7	32.7	74.8	124	108	0	34	32
2015	7	20	23	43	24	0.879	-0.072	4.534	0.01	0.007	0	38.7	32.7	74.4	125	108	0	35	32
2015	7	20	23	53	24	0.899	-0.069	4.534	0.013	0.01	0	38.3	32.7	75.3	124	108	0	35	32
2015	7	21	0	3	24	0.915	-0.098	4.534	0.01	0.007	0	38.7	32.7	74.8	124	108	0	34	32
2015	7	21	0	13	24	0.922	-0.072	4.534	0.01	0.007	0	39.1	33.1	74.8	125	109	0	34	32
2015	7	21	0	23	24	0.879	-0.089	4.534	0.01	0.007	0	39.1	32.7	74.4	125	108	0	34	32
2015	7	21	0	33	24	0.883	-0.079	4.534	0.01	0.007	0	39.6	33.1	71.8	125	108	0	33	31
2015	7	21	0	43	24	0.846	-0.105	4.534	0.01	0.007	0	39.1	33.1	74.4	125	108	0	34	31
2015	7	21	0	53	24	0.853	-0.085	4.534	0.01	0.007	0	39.1	32.7	74.4	125	108	0	34	32
2015	7	21	1	3	24	0.879	-0.072	4.534	0.01	0.007	0	39.1	32.7	74.4	125	108	0	34	32
2015	7	21	1	13	24	0.856	-0.089	4.531	0.01	0.007	0	39.1	32.7	74	125	108	0	34	32
2015	7	21	1	23	24	0.827	-0.075	4.531	0.01	0.007	0	39.1	33.1	74.4	125	108	0	34	31
2015	7	21	1	33	24	0.899	-0.079	4.531	0.01	0.007	0	38.3	32.7	74	124	107	0	35	31
2015	7	21	1	43	24	0.846	-0.098	4.531	0.01	0.007	0	39.1	33.1	73.5	125	108	0	34	31
2015	7	21	1	53	24	0.863	-0.066	4.524	0.01	0.007	0	38.7	32.7	73.1	124	108	0	34	32
2015	7	21	2	3	24	0.86	-0.102	4.524	0.01	0.007	0	38.7	32.7	74	124	107	0	34	31
2015	7	21	2	13	24	0.876	-0.079	4.521	0.013	0.01	0	38.7	33.1	72.7	124	108	0	34	31
2015	7	21	2	23	24	0.846	-0.082	4.521	0.01	0.007	0	39.1	33.1	71.4	125	108	0	34	31
2015	7	21	2	33	24	0.899	-0.075	4.521	0.01	0.007	0	38.7	32.7	74.4	124	108	0	34	32
2015	7	21	2	43	24	0.886	-0.079	4.518	0.01	0.007	0	38.7	32.7	74.4	124	108	0	34	32
2015	7	21	2	53	24	0.837	-0.118	4.518	0.01	0.007	0	38.7	33.1	74	124	108	0	34	31
2015	7	21	3	3	24	0.863	-0.082	4.518	0.013	0.01	0	38.7	32.7	74.4	124	107	0	34	31
2015	7	21	3	13	24	0.876	-0.079	4.514	0.01	0.007	0	39.1	32.7	74.8	124	108	0	33	32
2015	7	21	3	23	24	0.912	-0.112	4.514	0.01	0.007	0	38.7	32.7	74.4	124	107	0	34	31
2015	7	21	3	33	24	0.869	-0.102	4.514	0.01	0.007	0	38.7	32.7	75.3	124	108	0	34	32
2015	7	21	3	43	24	0.86	-0.085	4.514	0.01	0.007	0	38.7	32.7	75.3	124	108	0	34	32
2015	7	21	3	53	24	0.863	-0.079	4.514	0.01	0.007	0	38.7	32.3	75.3	124	107	0	34	32
2015	7	21	4	3	24	0.86	-0.108	4.511	0.01	0.007	0	38.3	32.3	75.3	123	107	0	34	32
2015	7	21	4	13	24	0.86	-0.069	4.511	0.01	0.007	0	37.8	32.7	75.7	123	107	0	35	31
2015	7	21	4	23	24	0.906	-0.105	4.511	0.01	0.007	0	38.3	32.7	76.1	123	107	0	34	31
2015	7	21	4	33	24	0.837	-0.075	4.511	0.01	0.007	0	39.1	33.1	76.1	125	109	0	34	32
2015	7	21	4	43	24	0.925	-0.069	4.511	0.01	0.007	0	39.1	32.3	76.1	124	107	0	33	32
2015	7	21	4	53	24	0.837	-0.095	4.508	0.01	0.007	0	39.1	33.1	76.5	125	109	0	34	32
2015	7	21	5	3	24	0.892	-0.098	4.508	0.013	0.01	0	39.6	32.7	76.5	125	108	0	33	32
2015	7	21	5	13	24	0.814	-0.079	4.508	0.01	0.007	0	39.6	33.1	76.5	126	109	0	34	32
2015	7	21	5	23	24	0.823	-0.082	4.505	0.01	0.007	0	39.1	32.7	76.1	125	108	0	34	32
2015	7	21	5	33	24	0.853	-0.102	4.505	0.01	0.007	0	39.1	33.5	76.5	125	109	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	21	5	43	24	0.843	-0.062	4.505	0.01	0.007	0	39.1	33.1	76.5	125	109	0	34	32
2015	7	21	5	53	24	0.873	-0.079	4.505	0.01	0.007	0	39.1	32.7	76.5	125	109	0	34	33
2015	7	21	6	3	24	0.876	-0.092	4.505	0.01	0.007	0	39.6	33.1	77	125	109	0	33	32
2015	7	21	6	13	24	0.846	-0.069	4.501	0.01	0.007	0	39.6	33.5	77	126	109	0	34	31
2015	7	21	6	23	24	0.863	-0.095	4.501	0.013	0.01	0	39.1	32.7	77.4	125	108	0	34	32
2015	7	21	6	33	24	0.892	-0.046	4.501	0.01	0.007	0	39.1	32.7	77	125	108	0	34	32
2015	7	21	6	43	24	0.866	-0.079	4.501	0.01	0.007	0	39.1	33.1	77.4	125	108	0	34	31
2015	7	21	6	53	24	0.856	-0.066	4.501	0.01	0.007	0	39.1	32.7	77.4	125	108	0	34	32
2015	7	21	7	3	24	0.873	-0.082	4.501	0.01	0.007	0	38.7	32.7	77.8	124	107	0	34	31
2015	7	21	7	13	24	0.86	-0.079	4.498	0.013	0.01	0	38.7	32.7	78.3	124	108	0	34	32
2015	7	21	7	23	24	0.883	-0.125	4.498	0.01	0.007	0	38.3	32.7	76.5	124	107	0	35	31
2015	7	21	7	33	24	0.837	-0.112	4.498	0.01	0.007	0	39.1	33.1	76.5	125	109	0	34	32
2015	7	21	7	43	24	0.82	-0.059	4.498	0.01	0.007	0	39.1	33.1	76.1	125	108	0	34	31
2015	7	21	7	53	24	0.863	-0.062	4.495	0.01	0.007	0	39.1	33.1	76.5	125	109	0	34	32
2015	7	21	8	3	24	0.85	-0.095	4.495	0.01	0.007	0	38.7	33.1	75.7	125	108	0	35	31
2015	7	21	8	13	24	0.82	-0.079	4.495	0.01	0.007	0	39.6	33.5	74.4	126	109	0	34	31
2015	7	21	8	23	24	0.879	-0.075	4.491	0.01	0.007	0	39.1	32.7	75.3	125	108	0	34	32
2015	7	21	8	33	24	0.853	-0.112	4.491	0.013	0.01	0	39.1	33.1	74.4	125	109	0	34	32
2015	7	21	8	43	24	0.892	-0.112	4.488	0.01	0.007	0	39.1	33.1	73.1	125	109	0	34	32
2015	7	21	8	53	24	0.899	-0.089	4.485	0.01	0.007	0	39.1	33.5	73.5	125	109	0	34	31
2015	7	21	9	3	24	0.856	-0.095	4.482	0.01	0.007	0	39.1	33.1	73.5	125	109	0	34	32
2015	7	21	9	13	24	0.84	-0.079	4.475	0.01	0.007	0	39.1	33.1	74	125	109	0	34	32
2015	7	21	9	23	24	0.873	-0.095	4.475	0.01	0.007	0	39.1	33.5	74	125	109	0	34	31
2015	7	21	9	33	24	0.863	-0.079	4.472	0.01	0.007	0	39.6	33.5	74.8	126	110	0	34	32
2015	7	21	9	43	24	0.85	-0.112	4.472	0.01	0.007	0	39.6	34	74.4	126	111	0	34	32
2015	7	21	9	53	24	0.85	-0.072	4.472	0.01	0.007	0	39.6	34	74.8	126	111	0	34	32
2015	7	21	10	3	24	0.85	-0.112	4.472	0.01	0.007	0	39.6	34	75.3	126	110	0	34	31
2015	7	21	10	13	24	0.823	-0.056	4.469	0.01	0.007	0	40	34	75.7	127	111	0	34	32
2015	7	21	10	23	24	0.833	-0.066	4.469	0.01	0.007	0	39.6	34	74.4	126	110	0	34	31
2015	7	21	10	33	24	0.804	-0.079	4.469	0.01	0.007	0	39.6	33.5	75.7	126	110	0	34	32
2015	7	21	10	43	24	0.807	-0.089	4.469	0.013	0.01	0	39.6	33.5	75.3	126	109	0	34	31
2015	7	21	10	53	24	0.843	-0.069	4.465	0.01	0.007	0	39.1	33.5	77	126	110	0	35	32
2015	7	21	11	3	24	0.84	-0.112	4.465	0.01	0.007	0	39.1	33.5	64.5	126	109	0	35	31
2015	7	21	11	13	24	0.869	-0.092	4.465	0.01	0.007	0	39.1	33.1	72.2	125	109	0	34	32
2015	7	21	11	23	24	0.85	-0.112	4.465	0.01	0.007	0	39.1	33.1	76.5	125	109	0	34	32
2015	7	21	11	33	24	0.866	-0.092	4.465	0.01	0.007	0	39.1	33.5	77	125	109	0	34	31
2015	7	21	11	43	24	0.856	-0.098	4.462	0.01	0.007	0	39.6	33.5	75.3	126	110	0	34	32
2015	7	21	11	53	24	0.85	-0.062	4.462	0.01	0.007	0	39.6	33.5	76.5	126	110	0	34	32
2015	7	21	12	3	24	0.82	-0.082	4.462	0.01	0.007	0	40	33.1	74.4	126	109	0	33	32
2015	7	21	12	13	24	0.846	-0.066	4.459	0.01	0.007	0	39.1	33.5	75.3	125	109	0	34	31
2015	7	21	12	23	24	0.86	-0.085	4.459	0.01	0.007	0	39.6	34	72.7	126	110	0	34	31
2015	7	21	12	33	24	0.83	-0.105	4.455	0.01	0.007	0	39.6	33.5	70.1	126	110	0	34	32
2015	7	21	12	43	24	0.82	-0.102	4.452	0.01	0.007	0	40	34	71	127	110	0	34	31
2015	7	21	12	53	24	0.794	-0.095	4.446	0.013	0.01	0	39.1	33.5	69.7	125	109	0	34	31
2015	7	21	13	3	24	0.876	-0.075	4.446	0.01	0.007	0	39.1	33.5	62.8	125	109	0	34	31
2015	7	21	13	13	24	0.853	-0.098	4.442	0.01	0.007	0	39.1	33.1	65.8	125	109	0	34	32
2015	7	21	13	23	24	0.814	-0.089	4.442	0.01	0.007	0	39.1	33.1	74.4	125	109	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	21	13	33	24	0.856	-0.075	4.439	0.01	0.007	0	40	34.4	71.4	127	111	0	34	31
2015	7	21	13	43	24	0.863	-0.105	4.439	0.01	0.007	0	39.6	33.5	72.2	126	110	0	34	32
2015	7	21	13	53	24	0.827	-0.085	4.436	0.01	0.007	0	39.6	33.5	65.8	126	109	0	34	31
2015	7	21	14	3	24	0.837	-0.105	4.436	0.01	0.007	0	39.1	33.5	74.8	125	109	0	34	31
2015	7	21	14	13	24	0.853	-0.072	4.436	0.013	0.01	0	39.1	33.5	60.2	125	109	0	34	31
2015	7	21	14	23	24	0.873	-0.105	4.436	0.01	0.007	0	38.7	32.7	69.7	124	108	0	34	32
2015	7	21	14	33	24	0.82	-0.082	4.436	0.01	0.007	0	39.1	33.5	76.1	125	109	0	34	31
2015	7	21	14	43	24	0.84	-0.131	4.432	0.013	0.01	0	39.1	32.7	64.9	125	108	0	34	32
2015	7	21	14	53	24	0.846	-0.066	4.432	0.01	0.007	0	38.7	33.5	59.3	125	109	0	35	31
2015	7	21	15	3	24	0.814	-0.082	4.432	0.01	0.007	0	39.1	33.1	63.6	125	108	0	34	31
2015	7	21	15	13	24	0.791	-0.131	4.432	0.01	0.007	0	38.7	33.1	71.8	124	108	0	34	31
2015	7	21	15	23	24	0.82	-0.098	4.429	0.01	0.007	0	39.1	32.7	69.2	125	108	0	34	32
2015	7	21	15	33	24	0.81	-0.082	4.429	0.01	0.007	0	39.1	33.5	74	125	109	0	34	31
2015	7	21	15	43	24	0.778	-0.085	4.426	0.01	0.007	0	38.7	33.1	67.1	124	108	0	34	31
2015	7	21	15	53	24	0.856	-0.085	4.426	0.01	0.007	0	38.3	33.1	65.8	124	108	0	35	31
2015	7	21	16	3	24	0.84	-0.092	4.423	0.01	0.007	0	39.6	33.1	56.8	126	109	0	34	32
2015	7	21	16	13	24	0.833	-0.112	4.423	0.01	0.007	0	38.7	32.7	60.2	124	108	0	34	32
2015	7	21	16	23	24	0.827	-0.082	4.419	0.01	0.007	0	39.1	32.7	65.8	124	108	0	33	32
2015	7	21	16	33	24	0.82	-0.095	4.416	0.01	0.007	0	38.7	32.7	70.5	124	107	0	34	31
2015	7	21	16	43	24	0.827	-0.092	4.413	0.01	0.007	0	38.3	32.7	73.5	123	107	0	34	31
2015	7	21	16	53	24	0.791	-0.075	4.409	0.016	0.013	0	38.3	33.1	73.1	124	109	0	35	32
2015	7	21	17	3	24	0.814	-0.089	4.406	0.013	0.01	0	39.1	33.1	71.4	125	108	0	34	31
2015	7	21	17	13	24	0.873	-0.095	4.406	0.01	0.007	0	39.1	33.1	75.3	125	108	0	34	31
2015	7	21	17	23	24	0.863	-0.082	4.406	0.01	0.007	0	38.7	33.1	74.8	124	108	0	34	31
2015	7	21	17	33	24	0.797	-0.082	4.406	0.01	0.007	0	39.1	33.5	76.1	125	109	0	34	31
2015	7	21	17	43	24	0.82	-0.098	4.406	0.013	0.01	0	39.1	33.1	76.1	125	109	0	34	32
2015	7	21	17	53	24	0.801	-0.092	4.406	0.01	0.007	0	39.1	33.5	77	125	109	0	34	31
2015	7	21	18	3	24	0.817	-0.092	4.403	0.01	0.007	0	39.1	33.1	74	125	108	0	34	31
2015	7	21	18	13	24	0.801	-0.108	4.403	0.01	0.007	0	39.1	33.1	67.9	125	109	0	34	32
2015	7	21	18	23	24	0.823	-0.095	4.403	0.01	0.007	0	39.6	34	76.1	126	110	0	34	31
2015	7	21	18	33	24	0.804	-0.082	4.403	0.01	0.007	0	39.6	34	77	126	110	0	34	31
2015	7	21	18	43	24	0.82	-0.105	4.4	0.01	0.007	0	39.6	33.5	75.3	125	110	0	33	32
2015	7	21	18	53	24	0.804	-0.089	4.4	0.01	0.007	0	39.6	34	55.9	126	110	0	34	31
2015	7	21	19	3	24	0.82	-0.098	4.4	0.01	0.007	0	40.4	34.4	56.3	127	111	0	33	31
2015	7	21	19	13	24	0.814	-0.105	4.4	0.01	0.007	0	40	35.3	58.9	127	112	0	34	30
2015	7	21	19	23	24	0.81	-0.095	4.396	0.013	0.01	0	40	34.8	61.9	127	112	0	34	31
2015	7	21	19	33	24	0.778	-0.069	4.4	0.01	0.007	0	40	34.4	69.7	127	112	0	34	32
2015	7	21	19	43	24	0.85	-0.095	4.4	0.013	0.01	0	39.6	34	77.4	126	111	0	34	32
2015	7	21	19	53	24	0.83	-0.079	4.396	0.013	0.01	0	39.1	34.4	73.1	126	111	0	35	31
2015	7	21	20	3	24	0.846	-0.082	4.396	0.01	0.007	0	40	34	77	127	111	0	34	32
2015	7	21	20	13	24	0.827	-0.069	4.396	0.01	0.007	0	40	34.4	76.1	127	111	0	34	31
2015	7	21	20	23	24	0.84	-0.052	4.396	0.013	0.01	0	39.6	34.4	76.1	126	111	0	34	31
2015	7	21	20	33	24	0.85	-0.075	4.396	0.01	0.007	0	40	34.4	76.5	127	111	0	34	31
2015	7	21	20	43	24	0.797	-0.105	4.396	0.01	0.007	0	39.6	34.4	75.7	126	111	0	34	31
2015	7	21	20	53	24	0.817	-0.092	4.396	0.01	0.007	0	40	34.8	77	127	112	0	34	31
2015	7	21	21	3	24	0.873	-0.062	4.396	0.01	0.007	0	39.1	34	77.8	126	110	0	35	31
2015	7	21	21	13	24	0.856	-0.085	4.393	0.01	0.007	0	39.6	34	77.8	126	110	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2	
2015	7	21	21	23	24	0.843	-0.069	4.393	0.01	0.007		0	39.1	34	76.1	125	110	0	34	31
2015	7	21	21	33	24	0.86	-0.102	4.393	0.01	0.007		0	39.6	34.4	78.3	126	111	0	34	31
2015	7	21	21	43	24	0.843	-0.069	4.393	0.01	0.007		0	40	34	77.8	126	110	0	33	31
2015	7	21	21	53	24	0.837	-0.105	4.393	0.01	0.007		0	39.6	34	77.8	126	110	0	34	31
2015	7	21	22	3	24	0.84	-0.062	4.393	0.01	0.007		0	39.6	34.4	77.8	126	111	0	34	31
2015	7	21	22	13	24	0.804	-0.062	4.393	0.01	0.007		0	40	34	77.4	126	111	0	33	32
2015	7	21	22	23	24	0.873	-0.105	4.39	0.01	0.007		0	39.6	33.5	77.4	126	110	0	34	32
2015	7	21	22	33	24	0.83	-0.089	4.39	0.01	0.007		0	39.6	34.4	77.4	126	111	0	34	31
2015	7	21	22	43	24	0.86	-0.108	4.39	0.01	0.007		0	39.6	34	77.4	126	111	0	34	32
2015	7	21	22	53	24	0.869	-0.105	4.39	0.013	0.01		0	39.1	33.5	76.5	125	110	0	34	32
2015	7	21	23	3	24	0.794	-0.036	4.39	0.01	0.007		0	39.6	34	77.4	126	111	0	34	32
2015	7	21	23	13	24	0.853	-0.066	4.39	0.016	0.013		0	40.4	34	75.7	126	111	0	32	32
2015	7	21	23	23	24	0.866	-0.079	4.386	0.013	0.01		0	39.6	34	75.3	126	111	0	34	32
2015	7	21	23	33	24	0.866	-0.102	4.386	0.01	0.007		0	39.6	34.4	76.5	126	111	0	34	31
2015	7	21	23	43	24	0.84	-0.066	4.386	0.01	0.007		0	39.6	34	76.1	126	110	0	34	31
2015	7	21	23	53	24	0.863	-0.105	4.386	0.013	0.01		0	40	34.4	75.7	127	111	0	34	31
2015	7	22	0	3	24	0.86	-0.102	4.386	0.01	0.007		0	40	34.8	76.1	127	112	0	34	31
2015	7	22	0	13	24	0.873	-0.082	4.386	0.01	0.007		0	40	34.4	75.3	127	111	0	34	31
2015	7	22	0	23	24	0.856	-0.046	4.383	0.01	0.007		0	40.4	34.8	75.3	128	112	0	34	31
2015	7	22	0	33	24	0.82	-0.072	4.383	0.01	0.007		0	40	34	75.7	127	111	0	34	32
2015	7	22	0	43	24	0.856	-0.082	4.383	0.01	0.007		0	40	34	74.8	127	111	0	34	32
2015	7	22	0	53	24	0.83	-0.089	4.383	0.01	0.007		0	40	34.4	74.4	127	111	0	34	31
2015	7	22	1	3	24	0.843	-0.059	4.383	0.01	0.007		0	40	34.4	74.8	127	111	0	34	31
2015	7	22	1	13	24	0.823	-0.079	4.383	0.01	0.007		0	39.6	34	72.7	126	110	0	34	31
2015	7	22	1	23	24	0.856	-0.075	4.38	0.01	0.007		0	40	34	74	127	111	0	34	32
2015	7	22	1	33	24	0.866	-0.112	4.38	0.01	0.007		0	40	34	74.4	127	111	0	34	32
2015	7	22	1	43	24	0.82	-0.112	4.38	0.013	0.01		0	40	34.8	74	127	111	0	34	30
2015	7	22	1	53	24	0.853	-0.102	4.377	0.013	0.01		0	39.6	34.4	73.5	127	111	0	35	31
2015	7	22	2	3	24	0.823	-0.079	4.373	0.01	0.007		0	39.6	34.4	72.7	126	111	0	34	31
2015	7	22	2	13	24	0.837	-0.125	4.37	0.01	0.007		0	39.6	34	73.5	126	110	0	34	31
2015	7	22	2	23	24	0.84	-0.072	4.37	0.01	0.007		0	40	34	74	127	111	0	34	32
2015	7	22	2	33	24	0.846	-0.079	4.367	0.013	0.01		0	39.6	34	74.4	126	111	0	34	32
2015	7	22	2	43	24	0.833	-0.079	4.367	0.01	0.007		0	40	34	74.4	126	110	0	33	31
2015	7	22	2	53	24	0.886	-0.092	4.367	0.01	0.007		0	39.6	34.8	74.8	126	111	0	34	30
2015	7	22	3	3	24	0.869	-0.118	4.364	0.01	0.007		0	39.1	33.5	74.4	125	109	0	34	31
2015	7	22	3	13	24	0.82	-0.102	4.364	0.01	0.007		0	40	34.4	75.3	127	111	0	34	31
2015	7	22	3	23	24	0.869	-0.092	4.364	0.01	0.007		0	39.6	34	74.8	126	110	0	34	31
2015	7	22	3	33	24	0.866	-0.089	4.364	0.01	0.007		0	39.6	34.4	74.8	127	111	0	35	31
2015	7	22	3	43	24	0.797	-0.095	4.364	0.01	0.007		0	40	34.4	75.3	127	111	0	34	31
2015	7	22	3	53	24	0.83	-0.082	4.36	0.01	0.007		0	40	34.4	75.3	127	112	0	34	32
2015	7	22	4	3	24	0.804	-0.095	4.36	0.01	0.007		0	40	34.4	75.3	127	111	0	34	31
2015	7	22	4	13	24	0.879	-0.098	4.36	0.01	0.007		0	40	34.4	75.7	127	111	0	34	31
2015	7	22	4	23	24	0.801	-0.079	4.36	0.01	0.007		0	40.4	34.4	75.3	128	112	0	34	32
2015	7	22	4	33	24	0.873	-0.079	4.36	0.01	0.007		0	40.4	34.8	75.7	128	112	0	34	31
2015	7	22	4	43	24	0.833	-0.079	4.357	0.01	0.007		0	40.4	35.3	75.7	128	113	0	34	31
2015	7	22	4	53	24	0.84	-0.148	4.357	0.013	0.01		0	40.4	34.4	76.1	128	112	0	34	32
2015	7	22	5	3	24	0.846	-0.079	4.357	0.01	0.007		0	40	34.8	76.1	128	112	0	35	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	22	5	13	24	0.85	-0.092	4.357	0.01	0.007	0	40.9	34.8	75.7	129	113	0	34	32
2015	7	22	5	23	24	0.81	-0.043	4.357	0.013	0.01	0	40.9	34.8	76.1	129	113	0	34	32
2015	7	22	5	33	24	0.843	-0.079	4.354	0.01	0.007	0	40.4	34.8	76.5	128	112	0	34	31
2015	7	22	5	43	24	0.833	-0.079	4.354	0.01	0.007	0	40.4	35.3	75.7	128	113	0	34	31
2015	7	22	5	53	24	0.817	-0.062	4.354	0.01	0.007	0	40.4	34.8	76.1	128	112	0	34	31
2015	7	22	6	3	24	0.83	-0.105	4.354	0.01	0.007	0	40.9	35.3	76.5	129	113	0	34	31
2015	7	22	6	13	24	0.82	-0.059	4.354	0.013	0.01	0	40.4	34.4	77	128	112	0	34	32
2015	7	22	6	23	24	0.82	-0.112	4.35	0.016	0.013	0	40.4	34.8	76.5	128	112	0	34	31
2015	7	22	6	33	24	0.817	-0.098	4.35	0.01	0.007	0	40.4	34.8	77.4	128	112	0	34	31
2015	7	22	6	43	24	0.778	-0.092	4.35	0.01	0.007	0	40.4	34.4	77	128	112	0	34	32
2015	7	22	6	53	24	0.814	-0.072	4.35	0.01	0.007	0	40.4	34.8	77.8	128	112	0	34	31
2015	7	22	7	3	24	0.801	-0.089	4.35	0.01	0.007	0	40.4	34.8	77	128	112	0	34	31
2015	7	22	7	13	24	0.837	-0.102	4.347	0.01	0.007	0	40	34.4	77.8	127	112	0	34	32
2015	7	22	7	23	24	0.846	-0.102	4.347	0.01	0.007	0	40	34	77.8	127	111	0	34	32
2015	7	22	7	33	24	0.817	-0.082	4.347	0.01	0.007	0	40	34	74.8	127	111	0	34	32
2015	7	22	7	43	24	0.794	-0.075	4.347	0.01	0.007	0	40	34.4	66.7	127	112	0	34	32
2015	7	22	7	53	24	0.82	-0.112	4.347	0.013	0.01	0	40	34.4	77.8	128	112	0	35	32
2015	7	22	8	3	24	0.856	-0.082	4.347	0.013	0.01	0	40	34.4	77.8	128	112	0	35	32
2015	7	22	8	13	24	0.843	-0.125	4.347	0.01	0.007	0	40	34.8	77.4	127	112	0	34	31
2015	7	22	8	23	24	0.833	-0.112	4.344	0.01	0.007	0	40.4	34.8	77.4	127	112	0	33	31
2015	7	22	8	33	24	0.817	-0.056	4.344	0.01	0.007	0	40.4	34.8	76.5	128	112	0	34	31
2015	7	22	8	43	24	0.853	-0.118	4.344	0.01	0.007	0	40.4	34.4	77.4	128	112	0	34	32
2015	7	22	8	53	24	0.82	-0.108	4.341	0.01	0.007	0	40.4	34.8	76.1	128	113	0	34	32
2015	7	22	9	3	24	0.83	-0.112	4.341	0.01	0.007	0	40.4	34.8	76.5	128	113	0	34	32
2015	7	22	9	13	24	0.83	-0.089	4.341	0.01	0.007	0	40.9	34.8	74.4	128	113	0	33	32
2015	7	22	9	23	24	0.817	-0.079	4.337	0.01	0.007	0	40.4	35.3	74.8	128	113	0	34	31
2015	7	22	9	33	24	0.837	-0.112	4.337	0.01	0.007	0	40	35.3	74.8	128	113	0	35	31
2015	7	22	9	43	24	0.84	-0.095	4.334	0.013	0.01	0	40	34.4	73.5	127	112	0	34	32
2015	7	22	9	53	24	0.833	-0.075	4.331	0.01	0.007	0	40.4	34.8	74	128	112	0	34	31
2015	7	22	10	3	24	0.83	-0.125	4.324	0.01	0.007	0	40.4	35.3	70.5	128	113	0	34	31
2015	7	22	10	13	24	0.837	-0.085	4.324	0.01	0.007	0	40.4	34.8	74.4	128	112	0	34	31
2015	7	22	10	23	24	0.827	-0.102	4.321	0.01	0.007	0	40.4	34.8	74.4	128	113	0	34	32
2015	7	22	10	33	24	0.814	-0.095	4.321	0.013	0.01	0	40.4	35.3	71	128	113	0	34	31
2015	7	22	10	43	24	0.801	-0.072	4.318	0.01	0.007	0	41.3	35.3	60.6	130	114	0	34	32
2015	7	22	10	53	24	0.833	-0.102	4.318	0.01	0.007	0	40.9	35.7	64.9	129	114	0	34	31
2015	7	22	11	3	24	0.804	-0.079	4.318	0.01	0.007	0	40.9	36.1	61.5	130	115	0	35	31
2015	7	22	11	13	24	0.794	-0.102	4.314	0.01	0.007	0	41.7	35.7	59.8	131	115	0	34	32
2015	7	22	11	23	24	0.804	-0.125	4.314	0.01	0.007	0	41.3	36.1	58	130	115	0	34	31
2015	7	22	11	33	24	0.817	-0.095	4.314	0.01	0.007	0	41.3	35.3	63.2	130	114	0	34	32
2015	7	22	11	43	24	0.791	-0.082	4.314	0.01	0.007	0	41.3	35.7	61.5	130	114	0	34	31
2015	7	22	11	53	24	0.837	-0.112	4.311	0.01	0.007	0	41.3	36.1	58.9	130	115	0	34	31
2015	7	22	12	3	24	0.774	-0.095	4.311	0.01	0.007	0	40.9	35.7	54.6	130	114	0	35	31
2015	7	22	12	13	24	0.807	-0.095	4.308	0.01	0.007	0	41.3	35.7	59.8	130	115	0	34	32
2015	7	22	12	23	24	0.771	-0.112	4.308	0.013	0.01	0	41.7	36.5	55.5	131	116	0	34	31
2015	7	22	12	33	24	0.774	-0.095	4.304	0.01	0.007	0	41.7	36.5	55	131	116	0	34	31
2015	7	22	12	43	24	0.771	-0.095	4.301	0.01	0.007	0	41.3	36.1	51.2	131	116	0	35	32
2015	7	22	12	53	24	0.751	-0.098	4.301	0.013	0.01	0	41.7	36.5	52.9	131	116	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	22	13	3	24	0.778	-0.075	4.298	0.01	0.007	0	41.7	36.5	52	131	116	0	34	31
2015	7	22	13	13	24	0.751	-0.098	4.295	0.01	0.007	0	41.7	36.1	53.8	131	116	0	34	32
2015	7	22	13	23	24	0.761	-0.059	4.291	0.01	0.007	0	42.1	36.5	53.3	132	117	0	34	32
2015	7	22	13	33	24	0.807	-0.115	4.288	0.01	0.007	0	41.7	36.5	54.6	131	116	0	34	31
2015	7	22	13	43	24	0.755	-0.138	4.288	0.01	0.007	0	41.7	36.5	54.6	131	116	0	34	31
2015	7	22	13	53	24	0.784	-0.098	4.288	0.01	0.007	0	41.3	36.5	54.2	131	116	0	35	31
2015	7	22	14	3	24	0.745	-0.069	4.285	0.01	0.007	0	41.7	36.1	54.6	132	116	0	35	32
2015	7	22	14	13	24	0.741	-0.092	4.281	0.01	0.007	0	42.1	36.1	53.8	132	116	0	34	32
2015	7	22	14	23	24	0.823	-0.102	4.281	0.01	0.007	0	41.7	36.5	52.9	131	116	0	34	31
2015	7	22	14	33	24	0.781	-0.098	4.281	0.01	0.007	0	42.1	37	55.9	132	117	0	34	31
2015	7	22	14	43	24	0.768	-0.098	4.278	0.01	0.007	0	42.1	36.5	55	132	117	0	34	32
2015	7	22	14	53	24	0.774	-0.095	4.278	0.01	0.007	0	41.7	36.1	52.5	132	116	0	35	32
2015	7	22	15	3	24	0.794	-0.089	4.275	0.01	0.007	0	41.7	36.5	53.8	131	116	0	34	31
2015	7	22	15	13	24	0.771	-0.079	4.275	0.01	0.007	0	41.7	36.1	55	131	116	0	34	32
2015	7	22	15	23	24	0.761	-0.075	4.272	0.01	0.007	0	41.7	36.1	55.9	131	115	0	34	31
2015	7	22	15	33	24	0.758	-0.095	4.272	0.01	0.007	0	41.3	35.7	51.2	130	115	0	34	32
2015	7	22	15	43	24	0.791	-0.062	4.268	0.01	0.007	0	41.3	35.3	53.3	129	114	0	33	32
2015	7	22	15	53	24	0.755	-0.095	4.268	0.01	0.007	0	41.3	36.1	54.2	130	115	0	34	31
2015	7	22	16	3	24	0.745	-0.085	4.262	0.01	0.007	0	40.9	35.7	52.9	129	114	0	34	31
2015	7	22	16	13	24	0.807	-0.092	4.259	0.01	0.007	0	40.9	35.3	54.6	129	114	0	34	32
2015	7	22	16	23	24	0.784	-0.092	4.259	0.01	0.007	0	40.9	35.3	52.5	128	113	0	33	31
2015	7	22	16	33	24	0.774	-0.108	4.255	0.01	0.007	0	40.9	35.7	55.5	129	114	0	34	31
2015	7	22	16	43	24	0.755	-0.098	4.252	0.01	0.007	0	40.9	35.3	55	129	114	0	34	32
2015	7	22	16	53	24	0.791	-0.118	4.249	0.01	0.007	0	40.9	35.3	55	129	114	0	34	32
2015	7	22	17	3	24	0.764	-0.095	4.249	0.01	0.007	0	40.9	34.8	55.9	129	113	0	34	32
2015	7	22	17	13	24	0.781	-0.115	4.245	0.01	0.007	0	40.9	35.3	67.1	129	113	0	34	31
2015	7	22	17	23	24	0.774	-0.098	4.245	0.01	0.007	0	40.9	35.7	55.5	129	114	0	34	31
2015	7	22	17	33	24	0.791	-0.092	4.242	0.01	0.007	0	40.9	35.3	58.5	129	114	0	34	32
2015	7	22	17	43	24	0.751	-0.108	4.242	0.013	0.01	0	39.1	36.1	57.2	125	115	0	34	31
2015	7	22	17	53	24	0.778	-0.079	4.242	0.01	0.007	0	41.3	35.7	61.9	130	114	0	34	31
2015	7	22	18	3	24	0.722	-0.128	4.239	0.01	0.007	0	40.9	35.3	64.5	129	113	0	34	31
2015	7	22	18	13	24	0.804	-0.115	4.242	0.01	0.007	0	40.9	35.3	64.9	129	113	0	34	31
2015	7	22	18	23	24	0.771	-0.098	4.239	0.01	0.007	0	40.9	35.7	59.3	129	114	0	34	31
2015	7	22	18	33	24	0.807	-0.108	4.239	0.01	0.007	0	40.9	35.7	60.6	129	114	0	34	31
2015	7	22	18	43	24	0.778	-0.108	4.236	0.01	0.007	0	41.3	36.5	56.8	130	115	0	34	30
2015	7	22	18	53	24	0.82	-0.105	4.236	0.01	0.007	0	41.3	35.7	63.2	130	115	0	34	32
2015	7	22	19	3	24	0.817	-0.118	4.236	0.01	0.007	0	41.3	35.7	62.8	130	114	0	34	31
2015	7	22	19	13	24	0.778	-0.085	4.232	0.01	0.007	0	41.3	35.7	58.5	131	115	0	35	32
2015	7	22	19	23	24	0.801	-0.102	4.232	0.01	0.007	0	42.1	36.1	60.2	131	115	0	33	31
2015	7	22	19	33	24	0.741	-0.102	4.229	0.01	0.007	0	41.3	36.1	63.6	130	115	0	34	31
2015	7	22	19	43	24	0.804	-0.121	4.232	0.01	0.007	0	41.3	35.7	73.5	130	114	0	34	31
2015	7	22	19	53	24	0.807	-0.112	4.229	0.01	0.007	0	41.3	36.1	67.1	130	115	0	34	31
2015	7	22	20	3	24	0.827	-0.098	4.222	0.01	0.007	0	41.3	35.3	61.5	130	114	0	34	32
2015	7	22	20	13	24	0.807	-0.098	4.222	0.013	0.01	0	41.3	35.7	64.1	130	115	0	34	32
2015	7	22	20	23	24	0.807	-0.082	4.222	0.013	0.01	0	41.3	35.7	71.8	130	115	0	34	32
2015	7	22	20	33	24	0.774	-0.089	4.219	0.01	0.007	0	41.7	35.7	69.2	130	114	0	33	31
2015	7	22	20	43	24	0.787	-0.095	4.213	0.01	0.007	0	41.3	35.3	68.8	130	114	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	22	20	53	24	0.817	-0.148	4.213	0.01	0.007	0	41.3	35.3	64.9	130	114	0	34	32
2015	7	22	21	3	24	0.745	-0.095	4.209	0.016	0.013	0	41.3	35.7	65.8	130	114	0	34	31
2015	7	22	21	13	24	0.784	-0.102	4.209	0.01	0.007	0	41.3	35.7	73.5	130	114	0	34	31
2015	7	22	21	23	24	0.771	-0.095	4.209	0.01	0.007	0	40.9	35.7	75.7	130	114	0	35	31
2015	7	22	21	33	24	0.823	-0.112	4.209	0.01	0.007	0	41.3	35.7	75.3	130	114	0	34	31
2015	7	22	21	43	24	0.791	-0.082	4.206	0.01	0.007	0	41.3	35.3	75.3	130	114	0	34	32
2015	7	22	21	53	24	0.791	-0.108	4.206	0.013	0.01	0	40.9	34.8	76.5	129	113	0	34	32
2015	7	22	22	3	24	0.807	-0.095	4.206	0.01	0.007	0	40.9	35.3	76.5	129	113	0	34	31
2015	7	22	22	13	24	0.807	-0.095	4.206	0.01	0.007	0	40.9	34.8	76.1	129	113	0	34	32
2015	7	22	22	23	24	0.81	-0.102	4.203	0.013	0.01	0	40.4	34.4	66.2	128	112	0	34	32
2015	7	22	22	33	24	0.797	-0.079	4.203	0.01	0.007	0	40.9	35.3	68.8	129	113	0	34	31
2015	7	22	22	43	24	0.794	-0.079	4.203	0.013	0.01	0	40.9	34.8	68.4	129	113	0	34	32
2015	7	22	22	53	24	0.751	-0.098	4.199	0.01	0.007	0	40.9	35.3	71.8	129	113	0	34	31
2015	7	22	23	3	24	0.784	-0.115	4.199	0.01	0.007	0	40.9	35.3	70.1	129	113	0	34	31
2015	7	22	23	13	24	0.741	-0.079	4.199	0.01	0.007	0	40.9	35.3	77.4	129	114	0	34	32
2015	7	22	23	23	24	0.807	-0.102	4.199	0.013	0.01	0	40.9	34.8	77.8	129	113	0	34	32
2015	7	22	23	33	24	0.801	-0.079	4.199	0.01	0.007	0	40.9	35.3	78.3	129	113	0	34	31
2015	7	22	23	43	24	0.804	-0.095	4.199	0.01	0.007	0	40.9	35.3	77.8	129	113	0	34	31
2015	7	22	23	53	24	0.81	-0.069	4.199	0.01	0.007	0	40.4	35.3	78.3	128	113	0	34	31
2015	7	23	0	3	24	0.794	-0.115	4.196	0.01	0.007	0	40.4	34.8	77.4	129	113	0	35	32
2015	7	23	0	13	24	0.745	-0.085	4.196	0.01	0.007	0	40.9	34.8	77	129	113	0	34	32
2015	7	23	0	23	24	0.774	-0.115	4.196	0.01	0.007	0	40.4	35.3	77	128	113	0	34	31
2015	7	23	0	33	24	0.787	-0.082	4.196	0.013	0.01	0	40.4	35.3	76.5	128	113	0	34	31
2015	7	23	0	43	24	0.797	-0.082	4.193	0.01	0.007	0	40	34.8	77.8	128	112	0	35	31
2015	7	23	0	53	24	0.807	-0.095	4.193	0.01	0.007	0	40.4	34.4	77	128	112	0	34	32
2015	7	23	1	3	24	0.755	-0.098	4.193	0.013	0.01	0	40.4	34.8	76.5	128	113	0	34	32
2015	7	23	1	13	24	0.771	-0.082	4.193	0.013	0.01	0	40	34.4	76.1	127	112	0	34	32
2015	7	23	1	23	24	0.771	-0.092	4.19	0.013	0.01	0	40	34.4	76.5	127	112	0	34	32
2015	7	23	1	33	24	0.807	-0.082	4.19	0.016	0.013	0	40.4	35.3	76.5	128	113	0	34	31
2015	7	23	1	43	24	0.804	-0.095	4.19	0.01	0.007	0	40.4	35.3	76.1	128	113	0	34	31
2015	7	23	1	53	24	0.794	-0.102	4.186	0.01	0.007	0	40.4	34.8	76.1	128	112	0	34	31
2015	7	23	2	3	24	0.817	-0.069	4.186	0.01	0.007	0	40.4	34.8	74.8	128	112	0	34	31
2015	7	23	2	13	24	0.781	-0.072	4.186	0.01	0.007	0	40.4	34.4	74.8	128	112	0	34	32
2015	7	23	2	23	24	0.81	-0.092	4.183	0.013	0.01	0	40.4	35.3	74.8	128	113	0	34	31
2015	7	23	2	33	24	0.823	-0.095	4.18	0.01	0.007	0	40	34.8	74.8	128	113	0	35	32
2015	7	23	2	43	24	0.817	-0.095	4.177	0.01	0.007	0	40.9	35.3	74.4	129	113	0	34	31
2015	7	23	2	53	24	0.807	-0.112	4.173	0.01	0.007	0	40.9	35.7	74	129	114	0	34	31
2015	7	23	3	3	24	0.807	-0.105	4.173	0.01	0.007	0	41.3	35.7	74.8	130	114	0	34	31
2015	7	23	3	13	24	0.817	-0.085	4.17	0.01	0.007	0	40.9	35.7	74.4	129	114	0	34	31
2015	7	23	3	23	24	0.778	-0.079	4.17	0.01	0.007	0	41.3	35.7	75.3	130	114	0	34	31
2015	7	23	3	33	24	0.817	-0.108	4.17	0.01	0.007	0	41.3	35.7	74.8	130	115	0	34	32
2015	7	23	3	43	24	0.82	-0.079	4.167	0.013	0.01	0	41.3	35.3	74.8	130	114	0	34	32
2015	7	23	3	53	24	0.814	-0.062	4.167	0.013	0.01	0	41.3	35.7	75.3	130	115	0	34	32
2015	7	23	4	3	24	0.784	-0.098	4.167	0.01	0.007	0	41.3	36.1	75.7	130	115	0	34	31
2015	7	23	4	13	24	0.84	-0.062	4.167	0.01	0.007	0	41.3	36.1	75.7	130	115	0	34	31
2015	7	23	4	23	24	0.787	-0.079	4.167	0.01	0.007	0	40.9	35.7	76.1	130	114	0	35	31
2015	7	23	4	33	24	0.82	-0.052	4.163	0.013	0.01	0	41.3	35.7	76.1	130	114	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	23	4	43	24	0.846	-0.089	4.163	0.013	0.01	0	41.3	35.7	76.5	130	114	0	34	31
2015	7	23	4	53	24	0.797	-0.112	4.163	0.01	0.007	0	40.9	35.3	77	129	113	0	34	31
2015	7	23	5	3	24	0.804	-0.066	4.163	0.013	0.01	0	41.3	35.7	77	130	115	0	34	32
2015	7	23	5	13	24	0.781	-0.089	4.163	0.01	0.007	0	41.3	35.7	77	130	115	0	34	32
2015	7	23	5	23	24	0.814	-0.056	4.16	0.01	0.007	0	41.7	35.7	77	131	115	0	34	32
2015	7	23	5	33	24	0.787	-0.069	4.16	0.01	0.007	0	41.3	36.1	76.5	130	115	0	34	31
2015	7	23	5	43	24	0.784	-0.049	4.16	0.013	0.01	0	41.7	36.1	77	131	116	0	34	32
2015	7	23	5	53	24	0.768	-0.079	4.16	0.01	0.007	0	41.7	35.7	77	131	115	0	34	32
2015	7	23	6	3	24	0.787	-0.075	4.16	0.01	0.007	0	41.7	35.7	77	131	115	0	34	32
2015	7	23	6	13	24	0.81	-0.102	4.16	0.01	0.007	0	41.3	35.3	77.8	130	114	0	34	32
2015	7	23	6	23	24	0.81	-0.059	4.157	0.01	0.007	0	41.7	36.5	77.8	131	116	0	34	31
2015	7	23	6	33	24	0.774	-0.079	4.157	0.01	0.007	0	41.3	36.1	77.4	130	115	0	34	31
2015	7	23	6	43	24	0.768	-0.108	4.157	0.01	0.007	0	41.3	35.7	77.4	130	114	0	34	31
2015	7	23	6	53	24	0.81	-0.092	4.157	0.01	0.007	0	41.3	35.3	78.3	130	114	0	34	32
2015	7	23	7	3	24	0.768	-0.069	4.157	0.01	0.007	0	41.7	36.1	78.3	130	115	0	33	31
2015	7	23	7	13	24	0.823	-0.079	4.154	0.01	0.007	0	41.3	35.3	77.4	130	114	0	34	32
2015	7	23	7	23	24	0.771	-0.082	4.154	0.01	0.007	0	41.3	35.3	76.5	130	114	0	34	32
2015	7	23	7	33	24	0.787	-0.118	4.154	0.01	0.007	0	41.3	35.7	77.8	129	114	0	33	31
2015	7	23	7	43	24	0.804	-0.102	4.154	0.01	0.007	0	41.3	35.3	77.8	130	114	0	34	32
2015	7	23	7	53	24	0.768	-0.082	4.154	0.013	0.01	0	40.9	34.8	74.8	129	113	0	34	32
2015	7	23	8	3	24	0.801	-0.092	4.154	0.01	0.007	0	40.4	35.7	74.8	129	114	0	35	31
2015	7	23	8	13	24	0.764	-0.105	4.154	0.01	0.007	0	40.9	35.3	74	129	114	0	34	32
2015	7	23	8	23	24	0.735	-0.108	4.154	0.01	0.007	0	41.3	35.7	72.7	130	114	0	34	31
2015	7	23	8	33	24	0.784	-0.112	4.15	0.01	0.007	0	41.3	35.7	70.5	129	114	0	33	31
2015	7	23	8	43	24	0.768	-0.095	4.15	0.01	0.007	0	41.3	35.7	74	130	115	0	34	32
2015	7	23	8	53	24	0.784	-0.098	4.15	0.013	0.01	0	41.3	35.7	72.7	130	115	0	34	32
2015	7	23	9	3	24	0.755	-0.125	4.15	0.013	0.01	0	41.3	36.5	74.8	131	116	0	35	31
2015	7	23	9	13	24	0.735	-0.092	4.15	0.01	0.007	0	41.7	35.7	65.4	131	115	0	34	32
2015	7	23	9	23	24	0.728	-0.085	4.15	0.01	0.007	0	41.3	36.1	61.1	131	116	0	35	32
2015	7	23	9	33	24	0.791	-0.098	4.147	0.01	0.007	0	42.1	36.1	62.8	132	116	0	34	32
2015	7	23	9	43	24	0.755	-0.112	4.147	0.01	0.007	0	42.1	37	59.8	132	117	0	34	31
2015	7	23	9	53	24	0.745	-0.112	4.147	0.01	0.007	0	42.1	36.5	71	131	116	0	33	31
2015	7	23	10	3	24	0.745	-0.102	4.144	0.013	0.01	0	41.3	36.5	62.8	131	116	0	35	31
2015	7	23	10	13	24	0.761	-0.075	4.144	0.013	0.01	0	42.6	36.1	67.5	132	116	0	33	32
2015	7	23	10	23	24	0.735	-0.115	4.14	0.01	0.007	0	41.7	36.5	66.2	131	116	0	34	31
2015	7	23	10	33	24	0.758	-0.105	4.137	0.01	0.007	0	42.1	36.1	70.1	132	116	0	34	32
2015	7	23	10	43	24	0.748	-0.105	4.134	0.01	0.007	0	41.7	36.5	73.1	131	116	0	34	31
2015	7	23	10	53	24	0.768	-0.098	4.131	0.01	0.007	0	41.7	35.7	67.5	131	115	0	34	32
2015	7	23	11	3	24	0.768	-0.102	4.131	0.01	0.007	0	41.7	36.1	71	131	115	0	34	31
2015	7	23	11	13	24	0.745	-0.092	4.131	0.01	0.007	0	41.3	35.7	70.5	130	115	0	34	32
2015	7	23	11	23	24	0.722	-0.079	4.127	0.01	0.007	0	41.3	35.3	70.1	130	114	0	34	32
2015	7	23	11	33	24	0.748	-0.079	4.127	0.01	0.007	0	42.1	36.5	73.5	131	116	0	33	31
2015	7	23	11	43	24	0.745	-0.092	4.127	0.013	0.01	0	41.7	36.1	58.9	131	116	0	34	32
2015	7	23	11	53	24	0.755	-0.115	4.127	0.01	0.007	0	41.3	35.7	62.4	130	115	0	34	32
2015	7	23	12	3	24	0.748	-0.089	4.127	0.01	0.007	0	40.9	36.1	63.6	130	115	0	35	31
2015	7	23	12	13	24	0.728	-0.125	4.124	0.013	0.01	0	41.7	36.1	61.9	131	115	0	34	31
2015	7	23	12	23	24	0.764	-0.112	4.124	0.01	0.007	0	41.3	36.1	58	130	115	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	23	12	33	24	0.738	-0.102	4.124	0.01	0.007	0	42.1	36.1	57.2	131	116	0	33	32
2015	7	23	12	43	24	0.758	-0.089	4.124	0.01	0.007	0	41.7	36.1	63.6	131	115	0	34	31
2015	7	23	12	53	24	0.741	-0.082	4.121	0.01	0.007	0	41.3	35.7	61.9	130	115	0	34	32
2015	7	23	13	3	24	0.715	-0.095	4.121	0.013	0.01	0	41.3	35.3	65.4	130	114	0	34	32
2015	7	23	13	13	24	0.761	-0.069	4.121	0.01	0.007	0	41.3	36.1	64.9	130	115	0	34	31
2015	7	23	13	23	24	0.741	-0.112	4.121	0.013	0.01	0	41.7	36.1	60.2	131	115	0	34	31
2015	7	23	13	33	24	0.774	-0.108	4.117	0.01	0.007	0	41.3	36.1	59.3	130	115	0	34	31
2015	7	23	13	43	24	0.745	-0.082	4.117	0.013	0.01	0	41.3	36.1	53.8	130	115	0	34	31
2015	7	23	13	53	24	0.725	-0.082	4.117	0.01	0.007	0	40.9	36.1	61.1	130	115	0	35	31
2015	7	23	14	3	24	0.732	-0.105	4.114	0.01	0.007	0	41.3	36.1	61.1	130	115	0	34	31
2015	7	23	14	13	24	0.735	-0.092	4.114	0.013	0.01	0	41.7	35.7	55	131	115	0	34	32
2015	7	23	14	23	24	0.735	-0.102	4.114	0.013	0.01	0	41.7	36.1	55.9	131	116	0	34	32
2015	7	23	14	33	24	0.728	-0.095	4.108	0.01	0.007	0	41.3	36.1	56.8	130	115	0	34	31
2015	7	23	14	43	24	0.745	-0.056	4.111	0.01	0.007	0	41.7	36.1	55	131	115	0	34	31
2015	7	23	14	53	24	0.728	-0.062	4.108	0.013	0.01	0	41.7	36.5	52.9	131	116	0	34	31
2015	7	23	15	3	24	0.712	-0.098	4.104	0.01	0.007	0	41.7	36.1	54.2	131	115	0	34	31
2015	7	23	15	13	24	0.764	-0.066	4.101	0.013	0.01	0	42.1	36.5	54.2	132	117	0	34	32
2015	7	23	15	23	24	0.758	-0.092	4.098	0.013	0.01	0	42.6	37.4	55.5	133	118	0	34	31
2015	7	23	15	33	24	0.764	-0.089	4.098	0.01	0.007	0	41.7	36.5	55.9	131	116	0	34	31
2015	7	23	15	43	24	0.709	-0.085	4.098	0.01	0.007	0	41.7	36.1	52.5	131	115	0	34	31
2015	7	23	15	53	24	0.758	-0.082	4.098	0.01	0.007	0	42.1	36.5	53.8	131	116	0	33	31
2015	7	23	16	3	24	0.735	-0.052	4.094	0.01	0.007	0	42.1	36.1	54.6	131	116	0	33	32
2015	7	23	16	13	24	0.728	-0.079	4.094	0.01	0.007	0	41.3	35.7	56.3	130	115	0	34	32
2015	7	23	16	23	24	0.738	-0.089	4.091	0.01	0.007	0	41.3	35.7	60.6	130	115	0	34	32
2015	7	23	16	33	24	0.735	-0.102	4.091	0.01	0.007	0	41.3	35.7	55	130	115	0	34	32
2015	7	23	16	43	24	0.725	-0.102	4.091	0.01	0.007	0	41.7	35.7	55.9	130	114	0	33	31
2015	7	23	16	53	24	0.728	-0.089	4.088	0.01	0.007	0	41.3	35.7	57.2	130	115	0	34	32
2015	7	23	17	3	24	0.794	-0.089	4.088	0.01	0.007	0	40.9	35.7	58.5	129	114	0	34	31
2015	7	23	17	13	24	0.712	-0.082	4.088	0.01	0.007	0	41.3	35.7	60.2	130	115	0	34	32
2015	7	23	17	23	24	0.728	-0.095	4.088	0.01	0.007	0	41.7	36.1	55	131	115	0	34	31
2015	7	23	17	33	24	0.745	-0.144	4.088	0.013	0.01	0	41.3	36.1	57.2	130	115	0	34	31
2015	7	23	17	43	24	0.758	-0.082	4.085	0.01	0.007	0	41.3	35.7	62.8	130	114	0	34	31
2015	7	23	17	53	24	0.771	-0.098	4.085	0.01	0.007	0	41.7	36.1	58	131	115	0	34	31
2015	7	23	18	3	24	0.715	-0.082	4.085	0.013	0.01	0	41.7	35.7	55.5	130	114	0	33	31
2015	7	23	18	13	24	0.712	-0.131	4.085	0.01	0.007	0	41.3	35.7	59.3	130	114	0	34	31
2015	7	23	18	23	24	0.702	-0.118	4.081	0.01	0.007	0	41.3	35.7	59.3	130	115	0	34	32
2015	7	23	18	33	24	0.741	-0.102	4.085	0.01	0.007	0	41.3	35.3	68.8	130	114	0	34	32
2015	7	23	18	43	24	0.728	-0.085	4.081	0.013	0.01	0	41.7	36.1	58.5	131	115	0	34	31
2015	7	23	18	53	24	0.774	-0.092	4.081	0.01	0.007	0	42.6	36.5	71.8	132	116	0	33	31
2015	7	23	19	3	24	0.768	-0.108	4.081	0.016	0.013	0	41.7	36.1	60.6	131	115	0	34	31
2015	7	23	19	13	24	0.794	-0.072	4.078	0.01	0.007	0	41.7	36.1	58.5	131	115	0	34	31
2015	7	23	19	23	24	0.745	-0.115	4.078	0.01	0.007	0	41.7	36.1	63.2	131	115	0	34	31
2015	7	23	19	33	24	0.709	-0.082	4.078	0.01	0.007	0	41.7	36.1	69.2	131	115	0	34	31
2015	7	23	19	43	24	0.741	-0.102	4.078	0.01	0.007	0	41.7	36.1	61.1	131	115	0	34	31
2015	7	23	19	53	24	0.768	-0.098	4.078	0.01	0.007	0	42.1	35.7	69.7	131	115	0	33	32
2015	7	23	20	3	24	0.768	-0.118	4.078	0.013	0.01	0	41.3	35.7	75.3	130	114	0	34	31
2015	7	23	20	13	24	0.722	-0.082	4.078	0.013	0.01	0	41.3	35.7	72.2	130	114	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	23	20	23	24	0.764	-0.095	4.075	0.01	0.007	0	41.7	35.7	66.2	131	114	0	34	31
2015	7	23	20	33	24	0.787	-0.095	4.075	0.01	0.007	0	41.3	35.3	63.2	130	114	0	34	32
2015	7	23	20	43	24	0.712	-0.075	4.072	0.01	0.007	0	41.7	35.7	55.9	131	115	0	34	32
2015	7	23	20	53	24	0.781	-0.082	4.072	0.01	0.007	0	41.7	35.7	53.3	131	115	0	34	32
2015	7	23	21	3	24	0.745	-0.125	4.068	0.013	0.01	0	42.1	35.7	57.2	131	114	0	33	31
2015	7	23	21	13	24	0.741	-0.059	4.068	0.01	0.007	0	41.7	35.3	55	131	114	0	34	32
2015	7	23	21	23	24	0.715	-0.056	4.068	0.013	0.01	0	41.7	36.1	56.8	131	115	0	34	31
2015	7	23	21	33	24	0.725	-0.082	4.068	0.01	0.007	0	41.7	35.7	57.2	131	115	0	34	32
2015	7	23	21	43	24	0.725	-0.059	4.065	0.01	0.007	0	41.7	36.1	58	131	115	0	34	31
2015	7	23	21	53	24	0.758	-0.112	4.065	0.01	0.007	0	41.7	36.1	55.9	131	115	0	34	31
2015	7	23	22	3	24	0.761	-0.108	4.065	0.016	0.013	0	41.7	36.1	60.6	130	115	0	33	31
2015	7	23	22	13	24	0.774	-0.102	4.065	0.01	0.007	0	40.9	35.3	63.2	129	114	0	34	32
2015	7	23	22	23	24	0.748	-0.098	4.068	0.01	0.007	0	41.3	35.3	74.4	130	114	0	34	32
2015	7	23	22	33	24	0.778	-0.092	4.065	0.01	0.007	0	40.9	35.7	74	129	114	0	34	31
2015	7	23	22	43	24	0.725	-0.115	4.062	0.013	0.01	0	41.3	35.7	70.1	130	114	0	34	31
2015	7	23	22	53	24	0.791	-0.098	4.062	0.01	0.007	0	41.3	35.7	66.7	129	114	0	33	31
2015	7	23	23	3	24	0.741	-0.112	4.062	0.01	0.007	0	40.9	35.3	74	129	113	0	34	31
2015	7	23	23	13	24	0.768	-0.092	4.062	0.013	0.01	0	40.9	35.3	74.8	129	113	0	34	31
2015	7	23	23	23	24	0.784	-0.108	4.058	0.01	0.007	0	40.4	35.7	73.1	129	114	0	35	31
2015	7	23	23	33	24	0.804	-0.131	4.058	0.01	0.007	0	40.9	34.8	73.5	128	112	0	33	31
2015	7	23	23	43	24	0.758	-0.115	4.058	0.01	0.007	0	40.4	34.8	68.8	128	112	0	34	31
2015	7	23	23	53	24	0.82	-0.082	4.058	0.01	0.007	0	40	34.4	72.7	128	112	0	35	32
2015	7	24	0	3	24	0.787	-0.039	4.058	0.013	0.01	0	40.9	35.3	72.7	129	113	0	34	31
2015	7	24	0	13	24	0.712	-0.118	4.055	0.01	0.007	0	40.9	35.3	63.6	129	113	0	34	31
2015	7	24	0	23	24	0.764	-0.121	4.055	0.01	0.007	0	40.4	34.8	64.1	128	112	0	34	31
2015	7	24	0	33	24	0.748	-0.121	4.055	0.01	0.007	0	40.9	34.8	74.8	128	113	0	33	32
2015	7	24	0	43	24	0.778	-0.075	4.055	0.01	0.007	0	40.9	35.3	74.4	129	113	0	34	31
2015	7	24	0	53	24	0.781	-0.095	4.055	0.01	0.007	0	41.3	35.7	75.3	130	114	0	34	31
2015	7	24	1	3	24	0.804	-0.095	4.055	0.01	0.007	0	40.4	35.3	73.5	129	113	0	35	31
2015	7	24	1	13	24	0.823	-0.098	4.055	0.01	0.007	0	40.9	35.3	74.8	129	113	0	34	31
2015	7	24	1	23	24	0.755	-0.092	4.055	0.013	0.01	0	40.9	35.3	75.3	129	113	0	34	31
2015	7	24	1	33	24	0.748	-0.095	4.055	0.01	0.007	0	41.7	35.3	75.3	130	114	0	33	32
2015	7	24	1	43	24	0.781	-0.098	4.052	0.01	0.007	0	41.3	35.7	74.8	130	114	0	34	31
2015	7	24	1	53	24	0.745	-0.098	4.052	0.01	0.007	0	40.9	34.8	75.7	129	113	0	34	32
2015	7	24	2	3	24	0.807	-0.112	4.052	0.01	0.007	0	40.9	34.8	75.3	129	113	0	34	32
2015	7	24	2	13	24	0.774	-0.049	4.052	0.01	0.007	0	40.9	35.3	76.1	129	113	0	34	31
2015	7	24	2	23	24	0.751	-0.115	4.052	0.013	0.01	0	40.9	34.8	75.7	129	113	0	34	32
2015	7	24	2	33	24	0.748	-0.098	4.052	0.013	0.01	0	40.9	35.3	75.3	129	114	0	34	32
2015	7	24	2	43	24	0.768	-0.102	4.052	0.013	0.01	0	41.7	35.7	74.8	130	114	0	33	31
2015	7	24	2	53	24	0.774	-0.095	4.052	0.013	0.01	0	41.3	35.7	75.7	130	114	0	34	31
2015	7	24	3	3	24	0.764	-0.098	4.052	0.013	0.01	0	41.7	36.1	75.3	131	115	0	34	31
2015	7	24	3	13	24	0.725	-0.072	4.052	0.01	0.007	0	41.3	35.7	75.7	130	115	0	34	32
2015	7	24	3	23	24	0.787	-0.066	4.052	0.01	0.007	0	41.7	36.1	76.1	131	115	0	34	31
2015	7	24	3	33	24	0.761	-0.112	4.052	0.01	0.007	0	40.9	35.3	76.1	129	114	0	34	32
2015	7	24	3	43	24	0.804	-0.102	4.052	0.01	0.007	0	41.3	35.7	76.1	130	114	0	34	31
2015	7	24	3	53	24	0.791	-0.128	4.052	0.013	0.01	0	41.3	35.7	76.1	130	114	0	34	31
2015	7	24	4	3	24	0.774	-0.089	4.052	0.013	0.01	0	41.3	36.1	76.1	130	115	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	24	4	13	24	0.755	-0.112	4.049	0.013	0.01	0	41.3	35.7	76.1	130	115	0	34	32
2015	7	24	4	23	24	0.771	-0.098	4.052	0.01	0.007	0	41.7	36.1	76.1	131	115	0	34	31
2015	7	24	4	33	24	0.758	-0.095	4.049	0.01	0.007	0	41.7	35.7	76.1	131	115	0	34	32
2015	7	24	4	43	24	0.768	-0.095	4.049	0.01	0.007	0	41.7	36.1	75.3	131	116	0	34	32
2015	7	24	4	53	24	0.768	-0.082	4.049	0.01	0.007	0	41.7	36.5	76.1	132	117	0	35	32
2015	7	24	5	3	24	0.745	-0.092	4.049	0.013	0.01	0	42.1	36.5	75.3	132	117	0	34	32
2015	7	24	5	13	24	0.801	-0.098	4.049	0.013	0.01	0	42.6	37	75.3	133	117	0	34	31
2015	7	24	5	23	24	0.774	-0.089	4.049	0.01	0.007	0	42.1	36.5	75.7	132	116	0	34	31
2015	7	24	5	33	24	0.784	-0.095	4.049	0.013	0.01	0	42.6	36.5	76.1	133	117	0	34	32
2015	7	24	5	43	24	0.745	-0.098	4.049	0.016	0.013	0	42.6	36.5	75.7	133	117	0	34	32
2015	7	24	5	53	24	0.761	-0.066	4.049	0.016	0.013	0	42.6	36.5	74.8	133	117	0	34	32
2015	7	24	6	3	24	0.768	-0.062	4.049	0.016	0.013	0	42.1	36.5	75.7	132	116	0	34	31
2015	7	24	6	13	24	0.774	-0.098	4.049	0.01	0.007	0	42.6	37	74.8	133	117	0	34	31
2015	7	24	6	23	24	0.741	-0.089	4.049	0.01	0.007	0	42.6	36.5	74.8	133	117	0	34	32
2015	7	24	6	33	24	0.751	-0.066	4.049	0.016	0.013	0	42.6	37.4	75.7	133	118	0	34	31
2015	7	24	6	43	24	0.732	-0.105	4.049	0.01	0.007	0	42.6	36.5	75.7	133	117	0	34	32
2015	7	24	6	53	24	0.748	-0.115	4.049	0.013	0.01	0	42.1	36.1	74.8	132	116	0	34	32
2015	7	24	7	3	24	0.787	-0.085	4.045	0.01	0.007	0	42.1	36.5	74.8	132	116	0	34	31
2015	7	24	7	13	24	0.778	-0.118	4.045	0.01	0.007	0	42.6	36.5	74.8	133	117	0	34	32
2015	7	24	7	23	24	0.758	-0.066	4.045	0.01	0.007	0	42.1	37	75.3	132	117	0	34	31
2015	7	24	7	33	24	0.764	-0.098	4.045	0.01	0.007	0	42.6	37	75.7	133	117	0	34	31
2015	7	24	7	43	24	0.797	-0.128	4.045	0.01	0.007	0	42.6	37	74.8	133	117	0	34	31
2015	7	24	7	53	24	0.764	-0.098	4.045	0.013	0.01	0	41.7	36.5	75.7	132	117	0	35	32
2015	7	24	8	3	24	0.791	-0.082	4.045	0.01	0.007	0	42.1	36.5	75.7	133	117	0	35	32
2015	7	24	8	13	24	0.764	-0.112	4.045	0.01	0.007	0	42.6	37	75.7	133	117	0	34	31
2015	7	24	8	23	24	0.755	-0.141	4.045	0.01	0.007	0	42.6	37	75.7	133	118	0	34	32
2015	7	24	8	33	24	0.735	-0.085	4.045	0.013	0.01	0	42.6	37	75.3	133	118	0	34	32
2015	7	24	8	43	24	0.781	-0.098	4.045	0.013	0.01	0	42.1	37	75.7	133	118	0	35	32
2015	7	24	8	53	24	0.774	-0.079	4.045	0.013	0.01	0	43	37	75.7	134	118	0	34	32
2015	7	24	9	3	24	0.768	-0.066	4.045	0.01	0.007	0	41.7	36.1	75.7	132	116	0	35	32
2015	7	24	9	13	24	0.761	-0.082	4.045	0.01	0.007	0	42.6	37	75.3	133	117	0	34	31
2015	7	24	9	23	24	0.771	-0.085	4.045	0.01	0.007	0	42.1	37	76.1	132	117	0	34	31
2015	7	24	9	33	24	0.741	-0.079	4.045	0.013	0.01	0	42.1	37	76.5	132	117	0	34	31
2015	7	24	9	43	24	0.768	-0.072	4.045	0.013	0.01	0	42.6	37.4	76.1	133	118	0	34	31
2015	7	24	9	53	24	0.748	-0.115	4.045	0.01	0.007	0	42.1	36.5	75.7	132	117	0	34	32
2015	7	24	10	3	24	0.745	-0.102	4.045	0.01	0.007	0	42.1	37	76.1	132	117	0	34	31
2015	7	24	10	13	24	0.774	-0.098	4.045	0.01	0.007	0	42.1	37	76.1	133	117	0	35	31
2015	7	24	10	23	24	0.751	-0.092	4.045	0.013	0.01	0	42.6	37	77	133	118	0	34	32
2015	7	24	10	33	24	0.774	-0.115	4.042	0.01	0.007	0	42.6	37	76.5	133	117	0	34	31
2015	7	24	10	43	24	0.732	-0.082	4.045	0.01	0.007	0	42.6	37	77	133	117	0	34	31
2015	7	24	10	53	24	0.745	-0.112	4.042	0.013	0.01	0	42.1	36.1	77	132	116	0	34	32
2015	7	24	11	3	24	0.748	-0.105	4.042	0.013	0.01	0	42.1	36.1	77	132	116	0	34	32
2015	7	24	11	13	24	0.751	-0.128	4.042	0.01	0.007	0	42.1	37	77.4	132	117	0	34	31
2015	7	24	11	23	24	0.751	-0.049	4.042	0.013	0.01	0	42.1	36.5	75.7	132	116	0	34	31
2015	7	24	11	33	24	0.784	-0.112	4.042	0.01	0.007	0	41.7	35.7	77.4	131	115	0	34	32
2015	7	24	11	43	24	0.764	-0.089	4.042	0.01	0.007	0	41.7	35.7	77.4	131	115	0	34	32
2015	7	24	11	53	24	0.738	-0.112	4.042	0.01	0.007	0	41.7	36.1	76.5	131	115	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	24	12	3	24	0.728	-0.102	4.042	0.01	0.007	0	42.6	37	76.1	133	117	0	34	31
2015	7	24	12	13	24	0.778	-0.131	4.042	0.013	0.01	0	42.1	36.1	77	132	116	0	34	32
2015	7	24	12	23	24	0.705	-0.102	4.042	0.01	0.007	0	42.1	36.1	76.5	132	116	0	34	32
2015	7	24	12	33	24	0.741	-0.082	4.042	0.01	0.007	0	42.1	37	76.5	132	117	0	34	31
2015	7	24	12	43	24	0.761	-0.082	4.042	0.01	0.007	0	43	37.4	78.7	134	118	0	34	31
2015	7	24	12	53	24	0.696	-0.115	4.042	0.01	0.007	0	42.1	37	78.3	133	117	0	35	31
2015	7	24	13	3	24	0.741	-0.085	4.042	0.01	0.007	0	42.6	36.5	67.5	133	117	0	34	32
2015	7	24	13	13	24	0.741	-0.082	4.042	0.013	0.01	0	42.6	37	78.3	133	118	0	34	32
2015	7	24	13	23	24	0.755	-0.092	4.042	0.01	0.007	0	42.1	36.5	72.2	132	116	0	34	31
2015	7	24	13	33	24	0.705	-0.131	4.042	0.01	0.007	0	42.6	37	75.7	133	117	0	34	31
2015	7	24	13	43	24	0.705	-0.082	4.042	0.013	0.01	0	42.6	37	65.8	133	117	0	34	31
2015	7	24	13	53	24	0.725	-0.121	4.042	0.01	0.007	0	42.1	37	77	132	117	0	34	31
2015	7	24	14	3	24	0.712	-0.098	4.042	0.013	0.01	0	42.1	37	76.5	132	117	0	34	31
2015	7	24	14	13	24	0.696	-0.125	4.042	0.016	0.016	0	42.1	36.5	61.9	132	117	0	34	32
2015	7	24	14	23	24	0.696	-0.118	4.042	0.01	0.007	0	42.1	36.1	70.5	132	116	0	34	32
2015	7	24	14	33	24	0.748	-0.112	4.042	0.01	0.007	0	42.1	37	76.1	132	117	0	34	31
2015	7	24	14	43	24	0.758	-0.082	4.042	0.01	0.007	0	42.6	36.5	70.1	133	117	0	34	32
2015	7	24	14	53	24	0.702	-0.085	4.039	0.01	0.007	0	42.1	36.5	62.4	132	117	0	34	32
2015	7	24	15	3	24	0.758	-0.095	4.039	0.01	0.007	0	42.6	37	62.4	133	117	0	34	31
2015	7	24	15	13	24	0.778	-0.079	4.039	0.013	0.01	0	42.6	36.5	58.5	133	117	0	34	32
2015	7	24	15	23	24	0.751	-0.082	4.042	0.01	0.007	0	42.6	37	76.1	133	117	0	34	31
2015	7	24	15	33	24	0.741	-0.112	4.039	0.013	0.01	0	42.1	36.5	61.1	132	117	0	34	32
2015	7	24	15	43	24	0.715	-0.089	4.042	0.01	0.007	0	42.1	36.5	76.1	132	116	0	34	31
2015	7	24	15	53	24	0.768	-0.115	4.042	0.01	0.007	0	42.1	36.5	74.4	132	116	0	34	31
2015	7	24	16	3	24	0.751	-0.082	4.042	0.016	0.016	0	41.7	36.5	75.7	131	116	0	34	31
2015	7	24	16	13	24	0.761	-0.072	4.042	0.016	0.013	0	42.1	36.5	72.7	132	117	0	34	32
2015	7	24	16	23	24	0.778	-0.098	4.042	0.01	0.007	0	42.6	36.1	78.3	132	116	0	33	32
2015	7	24	16	33	24	0.722	-0.089	4.042	0.01	0.007	0	42.1	36.5	61.9	132	116	0	34	31
2015	7	24	16	43	24	0.761	-0.092	4.042	0.01	0.007	0	42.1	37	74.8	132	117	0	34	31
2015	7	24	16	53	24	0.699	-0.095	4.042	0.01	0.007	0	42.1	36.5	61.1	132	116	0	34	31
2015	7	24	17	3	24	0.735	-0.108	4.042	0.013	0.01	0	42.1	36.1	68.8	132	116	0	34	32
2015	7	24	17	13	24	0.728	-0.085	4.042	0.01	0.007	0	42.6	37	68.4	132	117	0	33	31
2015	7	24	17	23	24	0.738	-0.079	4.042	0.01	0.007	0	42.6	37	63.2	133	117	0	34	31
2015	7	24	17	33	24	0.751	-0.085	4.042	0.01	0.007	0	42.1	36.5	71.4	132	117	0	34	32
2015	7	24	17	43	24	0.794	-0.102	4.042	0.016	0.013	0	42.1	36.1	58.9	132	116	0	34	32
2015	7	24	17	53	24	0.758	-0.092	4.042	0.013	0.01	0	42.6	36.1	59.8	132	116	0	33	32
2015	7	24	18	3	24	0.807	-0.092	4.045	0.01	0.007	0	42.1	37	66.7	132	117	0	34	31
2015	7	24	18	13	24	0.787	-0.098	4.045	0.013	0.01	0	41.7	36.5	68.8	132	116	0	35	31
2015	7	24	18	23	24	0.758	-0.118	4.045	0.01	0.007	0	41.7	36.5	72.2	132	116	0	35	31
2015	7	24	18	33	24	0.745	-0.125	4.045	0.01	0.007	0	42.1	36.1	72.2	132	116	0	34	32
2015	7	24	18	43	24	0.725	-0.105	4.045	0.01	0.007	0	42.1	36.5	74	132	116	0	34	31
2015	7	24	18	53	24	0.741	-0.098	4.045	0.01	0.007	0	41.7	36.5	77.8	131	116	0	34	31
2015	7	24	19	3	24	0.794	-0.092	4.045	0.013	0.01	0	42.1	36.1	77.4	132	116	0	34	32
2015	7	24	19	13	24	0.771	-0.089	4.049	0.01	0.007	0	42.6	36.5	77	132	116	0	33	31
2015	7	24	19	23	24	0.784	-0.075	4.049	0.01	0.007	0	42.1	37	76.5	132	117	0	34	31
2015	7	24	19	33	24	0.787	-0.066	4.049	0.01	0.007	0	43	37	77	133	117	0	33	31
2015	7	24	19	43	24	0.807	-0.062	4.049	0.01	0.007	0	42.6	37	76.5	133	118	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	24	19	53	24	0.764	-0.056	4.052	0.013	0.01	0	43	37.4	75.3	134	118	0	34	31
2015	7	24	20	3	24	0.758	-0.118	4.052	0.01	0.007	0	42.6	36.5	76.5	133	117	0	34	32
2015	7	24	20	13	24	0.787	-0.089	4.052	0.013	0.01	0	43	37.4	76.1	133	118	0	33	31
2015	7	24	20	23	24	0.709	-0.125	4.052	0.016	0.016	0	39.1	36.5	74	125	117	0	34	32
2015	7	24	20	33	24	0.774	-0.085	4.055	0.016	0.013	0	42.6	37.4	74.8	133	118	0	34	31
2015	7	24	20	43	24	0.728	-0.102	4.055	0.01	0.007	0	42.6	37	74	133	117	0	34	31
2015	7	24	20	53	24	0.83	-0.098	4.058	0.01	0.007	0	42.6	36.5	74.4	133	117	0	34	32
2015	7	24	21	3	24	0.768	-0.115	4.058	0.01	0.007	0	43	36.1	73.5	133	116	0	33	32
2015	7	24	21	13	24	0.745	-0.066	4.062	0.013	0.01	0	42.6	37	73.5	133	117	0	34	31
2015	7	24	21	23	24	0.82	-0.056	4.068	0.01	0.007	0	42.1	36.5	74	132	116	0	34	31
2015	7	24	21	33	24	0.797	-0.098	4.072	0.01	0.007	0	42.6	37	74	133	117	0	34	31
2015	7	24	21	43	24	0.761	-0.066	4.075	0.013	0.01	0	42.6	37	74.8	133	117	0	34	31
2015	7	24	21	53	24	0.778	-0.092	4.075	0.013	0.01	0	42.1	36.1	76.1	132	116	0	34	32
2015	7	24	22	3	24	0.741	-0.115	4.075	0.016	0.016	0	42.6	36.1	76.1	132	116	0	33	32
2015	7	24	22	13	24	0.787	-0.125	4.078	0.016	0.013	0	41.7	36.1	76.5	131	115	0	34	31
2015	7	24	22	23	24	0.807	-0.072	4.078	0.01	0.007	0	41.7	36.1	77	131	115	0	34	31
2015	7	24	22	33	24	0.774	-0.072	4.078	0.013	0.01	0	42.1	36.5	77.8	132	116	0	34	31
2015	7	24	22	43	24	0.761	-0.108	4.081	0.013	0.01	0	41.7	36.1	77.4	131	115	0	34	31
2015	7	24	22	53	24	0.787	-0.108	4.081	0.01	0.007	0	42.1	36.1	77.8	132	116	0	34	32
2015	7	24	23	3	24	0.764	-0.105	4.081	0.01	0.007	0	41.7	36.1	77.8	131	115	0	34	31
2015	7	24	23	13	24	0.814	-0.098	4.081	0.01	0.007	0	41.7	35.7	77.8	131	115	0	34	32
2015	7	24	23	23	24	0.771	-0.112	4.081	0.01	0.007	0	42.1	36.1	77.4	132	115	0	34	31
2015	7	24	23	33	24	0.784	-0.085	4.085	0.01	0.007	0	41.3	35.3	77.4	130	114	0	34	32
2015	7	24	23	43	24	0.771	-0.118	4.085	0.01	0.007	0	41.7	36.1	75.7	131	115	0	34	31
2015	7	24	23	53	24	0.797	-0.095	4.085	0.01	0.007	0	41.3	35.7	75.7	130	114	0	34	31
2015	7	25	0	3	24	0.784	-0.118	4.088	0.013	0.01	0	41.3	35.3	75.3	130	114	0	34	32
2015	7	25	0	13	24	0.774	-0.069	4.088	0.016	0.013	0	42.1	35.7	76.5	131	114	0	33	31
2015	7	25	0	23	24	0.761	-0.115	4.088	0.01	0.007	0	41.3	35.7	76.1	130	114	0	34	31
2015	7	25	0	33	24	0.804	-0.089	4.091	0.01	0.007	0	42.1	35.3	74.8	131	114	0	33	32
2015	7	25	0	43	24	0.837	-0.112	4.091	0.01	0.007	0	41.3	35.7	76.1	130	114	0	34	31
2015	7	25	0	53	24	0.804	-0.085	4.091	0.013	0.01	0	41.7	36.1	74.8	131	115	0	34	31
2015	7	25	1	3	24	0.801	-0.108	4.091	0.01	0.007	0	41.3	36.1	73.5	130	115	0	34	31
2015	7	25	1	13	24	0.81	-0.102	4.098	0.01	0.007	0	41.7	35.3	74	130	114	0	33	32
2015	7	25	1	23	24	0.787	-0.095	4.104	0.01	0.007	0	42.1	35.7	74	131	115	0	33	32
2015	7	25	1	33	24	0.804	-0.062	4.108	0.01	0.007	0	41.7	36.5	74.4	131	116	0	34	31
2015	7	25	1	43	24	0.791	-0.105	4.108	0.013	0.01	0	41.7	36.1	74.8	131	115	0	34	31
2015	7	25	1	53	24	0.771	-0.095	4.111	0.01	0.007	0	41.7	36.5	76.1	131	116	0	34	31
2015	7	25	2	3	24	0.771	-0.085	4.111	0.01	0.007	0	42.6	36.5	76.5	132	117	0	33	32
2015	7	25	2	13	24	0.787	-0.085	4.111	0.01	0.007	0	42.1	36.1	76.5	132	116	0	34	32
2015	7	25	2	23	24	0.768	-0.105	4.114	0.01	0.007	0	41.7	36.5	77	131	116	0	34	31
2015	7	25	2	33	24	0.755	-0.075	4.114	0.01	0.007	0	42.1	36.1	77.8	132	116	0	34	32
2015	7	25	2	43	24	0.807	-0.095	4.117	0.01	0.007	0	41.7	36.1	78.3	132	116	0	35	32
2015	7	25	2	53	24	0.797	-0.079	4.117	0.013	0.01	0	42.1	36.5	78.3	132	116	0	34	31
2015	7	25	3	3	24	0.797	-0.082	4.117	0.01	0.007	0	41.7	36.1	78.3	131	116	0	34	32
2015	7	25	3	13	24	0.804	-0.125	4.117	0.01	0.007	0	42.1	36.1	77.8	132	115	0	34	31
2015	7	25	3	23	24	0.814	-0.121	4.117	0.013	0.01	0	41.7	36.5	77.4	131	116	0	34	31
2015	7	25	3	33	24	0.774	-0.089	4.117	0.01	0.007	0	41.7	36.1	77	131	115	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	25	3	43	24	0.801	-0.108	4.117	0.01	0.007	0	42.1	36.1	76.5	132	116	0	34	32
2015	7	25	3	53	24	0.755	-0.085	4.117	0.01	0.007	0	42.6	36.5	76.5	133	116	0	34	31
2015	7	25	4	3	24	0.758	-0.098	4.121	0.01	0.007	0	41.7	36.1	77	131	116	0	34	32
2015	7	25	4	13	24	0.804	-0.079	4.121	0.01	0.007	0	41.7	36.5	76.5	132	116	0	35	31
2015	7	25	4	23	24	0.814	-0.112	4.121	0.013	0.01	0	42.1	36.5	77.4	132	116	0	34	31
2015	7	25	4	33	24	0.758	-0.066	4.121	0.01	0.007	0	42.1	36.5	77	132	116	0	34	31
2015	7	25	4	43	24	0.784	-0.075	4.124	0.01	0.007	0	42.1	36.5	76.5	132	116	0	34	31
2015	7	25	4	53	24	0.778	-0.079	4.124	0.013	0.01	0	42.1	36.1	76.1	132	116	0	34	32
2015	7	25	5	3	24	0.801	-0.095	4.124	0.01	0.007	0	41.7	36.1	75.7	132	116	0	35	32
2015	7	25	5	13	24	0.797	-0.079	4.124	0.016	0.013	0	41.7	36.5	75.7	132	116	0	35	31
2015	7	25	5	23	24	0.794	-0.079	4.124	0.01	0.007	0	42.6	36.5	75.3	133	117	0	34	32
2015	7	25	5	33	24	0.764	-0.085	4.127	0.016	0.013	0	43	37	73.1	133	117	0	33	31
2015	7	25	5	43	24	0.804	-0.075	4.131	0.01	0.007	0	42.6	36.5	74.4	133	117	0	34	32
2015	7	25	5	53	24	0.784	-0.098	4.134	0.01	0.007	0	42.6	37.4	74	133	118	0	34	31
2015	7	25	6	3	24	0.778	-0.102	4.137	0.01	0.007	0	42.6	36.5	75.3	133	117	0	34	32
2015	7	25	6	13	24	0.807	-0.089	4.14	0.01	0.007	0	42.1	36.5	74.4	133	117	0	35	32
2015	7	25	6	23	24	0.784	-0.066	4.14	0.013	0.01	0	42.6	36.5	75.3	133	117	0	34	32
2015	7	25	6	33	24	0.768	-0.128	4.144	0.01	0.007	0	42.1	36.5	76.1	132	117	0	34	32
2015	7	25	6	43	24	0.814	-0.079	4.144	0.016	0.013	0	42.6	37	77	133	117	0	34	31
2015	7	25	6	53	24	0.781	-0.082	4.144	0.01	0.007	0	42.6	36.5	76.1	133	117	0	34	32
2015	7	25	7	3	24	0.797	-0.092	4.144	0.01	0.007	0	42.1	36.1	77.4	132	116	0	34	32
2015	7	25	7	13	24	0.784	-0.066	4.147	0.013	0.01	0	41.7	36.1	77.8	132	116	0	35	32
2015	7	25	7	23	24	0.797	-0.082	4.147	0.01	0.007	0	42.1	36.5	76.5	132	117	0	34	32
2015	7	25	7	33	24	0.778	-0.095	4.147	0.013	0.01	0	42.1	36.5	78.3	132	116	0	34	31
2015	7	25	7	43	24	0.794	-0.108	4.147	0.013	0.01	0	42.1	36.5	78.3	133	117	0	35	32
2015	7	25	7	53	24	0.817	-0.095	4.15	0.013	0.01	0	42.6	37	79.1	133	118	0	34	32
2015	7	25	8	3	24	0.81	-0.062	4.15	0.01	0.007	0	42.1	37	79.6	132	117	0	34	31
2015	7	25	8	13	24	0.827	-0.079	4.15	0.013	0.01	0	42.1	37.4	78.3	133	118	0	35	31
2015	7	25	8	23	24	0.83	-0.102	4.15	0.01	0.007	0	42.6	36.5	78.7	133	117	0	34	32
2015	7	25	8	33	24	0.764	-0.092	4.15	0.01	0.007	0	42.6	36.5	78.7	133	117	0	34	32
2015	7	25	8	43	24	0.81	-0.095	4.15	0.01	0.007	0	43	36.5	78.7	133	117	0	33	32
2015	7	25	8	53	24	0.797	-0.079	4.15	0.01	0.007	0	42.1	36.1	78.7	132	116	0	34	32
2015	7	25	9	3	24	0.801	-0.072	4.15	0.01	0.007	0	42.1	36.5	78.7	132	117	0	34	32
2015	7	25	9	13	24	0.81	-0.069	4.154	0.01	0.007	0	42.1	36.5	77.4	132	117	0	34	32
2015	7	25	9	23	24	0.801	-0.105	4.154	0.016	0.013	0	41.3	36.1	78.3	131	116	0	35	32
2015	7	25	9	33	24	0.781	-0.069	4.154	0.01	0.007	0	41.7	36.1	78.7	131	116	0	34	32
2015	7	25	9	43	24	0.781	-0.115	4.154	0.013	0.01	0	41.7	36.1	77.8	131	116	0	34	32
2015	7	25	9	53	24	0.771	-0.043	4.154	0.01	0.007	0	41.7	36.1	78.3	131	115	0	34	31
2015	7	25	10	3	24	0.755	-0.112	4.154	0.01	0.007	0	41.7	36.1	78.7	131	115	0	34	31
2015	7	25	10	13	24	0.778	-0.118	4.154	0.01	0.007	0	42.1	36.5	78.7	132	116	0	34	31
2015	7	25	10	23	24	0.774	-0.089	4.154	0.013	0.01	0	41.3	36.1	77.4	131	116	0	35	32
2015	7	25	10	33	24	0.784	-0.112	4.154	0.01	0.007	0	42.1	36.1	77.4	132	116	0	34	32
2015	7	25	10	43	24	0.764	-0.089	4.157	0.01	0.007	0	41.7	36.5	77.8	132	116	0	35	31
2015	7	25	10	53	24	0.797	-0.085	4.157	0.01	0.007	0	42.1	36.5	77.4	132	116	0	34	31
2015	7	25	11	3	24	0.781	-0.098	4.157	0.01	0.007	0	42.1	36.1	76.1	132	116	0	34	32
2015	7	25	11	13	24	0.787	-0.069	4.157	0.01	0.007	0	41.7	35.7	78.3	131	115	0	34	32
2015	7	25	11	23	24	0.771	-0.108	4.157	0.013	0.01	0	41.7	36.1	77.4	131	115	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	25	11	33	24	0.748	-0.112	4.157	0.01	0.007	0	42.1	36.5	77	132	117	0	34	32
2015	7	25	11	43	24	0.758	-0.079	4.157	0.013	0.01	0	42.1	36.5	70.5	132	117	0	34	32
2015	7	25	11	53	24	0.768	-0.131	4.157	0.01	0.007	0	42.1	36.5	74.8	132	116	0	34	31
2015	7	25	12	3	24	0.787	-0.141	4.157	0.013	0.01	0	42.1	37	73.5	132	117	0	34	31
2015	7	25	12	13	24	0.755	-0.098	4.157	0.01	0.007	0	42.1	36.5	62.4	132	116	0	34	31
2015	7	25	12	23	24	0.791	-0.112	4.157	0.01	0.007	0	41.7	35.7	77	131	115	0	34	32
2015	7	25	12	33	24	0.748	-0.072	4.157	0.01	0.007	0	42.1	36.5	72.2	132	116	0	34	31
2015	7	25	12	43	24	0.784	-0.069	4.157	0.01	0.007	0	42.1	36.5	70.1	132	116	0	34	31
2015	7	25	12	53	24	0.741	-0.066	4.157	0.01	0.007	0	41.7	35.7	75.3	132	115	0	35	32
2015	7	25	13	3	24	0.781	-0.089	4.15	0.01	0.007	0	45.2	38.3	46.9	139	121	0	34	32
2015	7	25	13	13	24	0.768	-0.075	4.157	0.01	0.007	0	42.1	36.5	62.4	132	117	0	34	32
2015	7	25	13	23	24	0.728	-0.115	4.154	0.01	0.007	0	42.1	35.7	58.5	131	115	0	33	32
2015	7	25	13	33	24	0.758	-0.095	4.154	0.01	0.007	0	44.3	38.3	55.5	137	121	0	34	32
2015	7	25	13	43	24	0.751	-0.125	4.157	0.01	0.007	0	46	40	68.4	141	125	0	34	32
2015	7	25	13	53	24	0.804	-0.095	4.157	0.01	0.007	0	44.7	39.1	65.8	138	122	0	34	31
2015	7	25	14	3	24	0.751	-0.085	4.157	0.016	0.016	0	43.4	37.8	61.1	135	119	0	34	31
2015	7	25	14	13	24	0.741	-0.075	4.15	0.013	0.01	0	46	40.4	48.6	141	126	0	34	32
2015	7	25	14	23	24	0.771	-0.085	4.154	0.013	0.01	0	43	37	56.3	134	118	0	34	32
2015	7	25	14	33	24	0.755	-0.095	4.157	0.01	0.007	0	41.7	35.7	69.7	131	115	0	34	32
2015	7	25	14	43	24	0.764	-0.066	4.157	0.01	0.007	0	41.7	35.7	68.8	131	115	0	34	32
2015	7	25	14	53	24	0.741	-0.089	4.154	0.01	0.007	0	41.7	36.5	54.2	132	116	0	35	31
2015	7	25	15	3	24	0.755	-0.082	4.154	0.01	0.007	0	42.1	36.1	64.5	132	116	0	34	32
2015	7	25	15	13	24	0.745	-0.125	4.154	0.01	0.007	0	42.6	36.1	58	132	116	0	33	32
2015	7	25	15	23	24	0.719	-0.075	4.154	0.01	0.007	0	41.7	36.1	55.9	131	116	0	34	32
2015	7	25	15	33	24	0.784	-0.069	4.154	0.013	0.01	0	41.7	36.1	55.5	131	115	0	34	31
2015	7	25	15	43	24	0.758	-0.095	4.154	0.013	0.01	0	41.7	36.1	58.5	131	116	0	34	32
2015	7	25	15	53	24	0.807	-0.079	4.154	0.01	0.007	0	41.7	36.5	58.9	131	116	0	34	31
2015	7	25	16	3	24	0.784	-0.092	4.15	0.01	0.007	0	42.1	36.5	55.9	131	116	0	33	31
2015	7	25	16	13	24	0.781	-0.112	4.15	0.01	0.007	0	42.1	36.1	53.3	132	116	0	34	32
2015	7	25	16	23	24	0.764	-0.072	4.15	0.01	0.007	0	42.1	37	58.9	132	117	0	34	31
2015	7	25	16	33	24	0.774	-0.115	4.15	0.013	0.01	0	42.1	36.5	57.6	132	117	0	34	32
2015	7	25	16	43	24	0.784	-0.135	4.15	0.01	0.007	0	42.1	36.5	60.6	132	117	0	34	32
2015	7	25	16	53	24	0.725	-0.095	4.147	0.016	0.013	0	41.7	35.7	56.3	131	115	0	34	32
2015	7	25	17	3	24	0.758	-0.095	4.147	0.01	0.007	0	42.1	36.1	56.8	131	115	0	33	31
2015	7	25	17	13	24	0.787	-0.089	4.15	0.013	0.01	0	42.1	36.1	67.9	131	115	0	33	31
2015	7	25	17	23	24	0.764	-0.079	4.147	0.01	0.007	0	41.7	35.7	62.4	131	115	0	34	32
2015	7	25	17	33	24	0.761	-0.108	4.147	0.013	0.01	0	42.1	36.5	62.8	132	116	0	34	31
2015	7	25	17	43	24	0.784	-0.092	4.147	0.01	0.007	0	42.1	36.5	56.8	132	116	0	34	31
2015	7	25	17	53	24	0.768	-0.115	4.144	0.01	0.007	0	41.7	36.1	60.2	131	115	0	34	31
2015	7	25	18	3	24	0.768	-0.108	4.147	0.013	0.01	0	41.7	36.1	68.4	131	115	0	34	31
2015	7	25	18	13	24	0.768	-0.092	4.147	0.01	0.007	0	42.6	36.5	71.8	132	116	0	33	31
2015	7	25	18	23	24	0.774	-0.098	4.147	0.01	0.007	0	42.1	35.7	69.2	132	115	0	34	32
2015	7	25	18	33	24	0.778	-0.098	4.147	0.01	0.007	0	41.7	36.1	66.2	131	115	0	34	31
2015	7	25	18	43	24	0.771	-0.049	4.144	0.01	0.007	0	41.7	36.1	68.8	131	115	0	34	31
2015	7	25	18	53	24	0.794	-0.108	4.147	0.013	0.01	0	41.7	36.1	72.7	131	115	0	34	31
2015	7	25	19	3	24	0.827	-0.085	4.147	0.01	0.007	0	41.3	35.3	74	130	114	0	34	32
2015	7	25	19	13	24	0.738	-0.115	4.147	0.01	0.007	0	41.7	36.1	73.1	131	115	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	25	19	23	24	0.774	-0.089	4.147	0.01	0.007	0	41.7	36.1	74.4	131	115	0	34	31
2015	7	25	19	33	24	0.787	-0.089	4.147	0.01	0.007	0	41.3	36.1	74.8	130	115	0	34	31
2015	7	25	19	43	24	0.774	-0.098	4.15	0.013	0.01	0	41.3	35.7	74.8	130	114	0	34	31
2015	7	25	19	53	24	0.784	-0.102	4.15	0.01	0.007	0	41.3	35.7	74.8	130	114	0	34	31
2015	7	25	20	3	24	0.804	-0.098	4.147	0.013	0.01	0	41.7	35.7	74	130	114	0	33	31
2015	7	25	20	13	24	0.768	-0.075	4.15	0.01	0.007	0	41.3	35.3	76.1	130	114	0	34	32
2015	7	25	20	23	24	0.807	-0.075	4.15	0.016	0.013	0	40.9	35.7	75.3	130	114	0	35	31
2015	7	25	20	33	24	0.794	-0.062	4.15	0.01	0.007	0	41.3	35.7	75.7	130	114	0	34	31
2015	7	25	20	43	24	0.804	-0.095	4.15	0.013	0.01	0	41.3	35.7	73.5	130	114	0	34	31
2015	7	25	20	53	24	0.814	-0.079	4.15	0.01	0.007	0	41.3	35.7	74.4	130	114	0	34	31
2015	7	25	21	3	24	0.823	-0.098	4.15	0.01	0.007	0	41.3	35.3	75.7	130	113	0	34	31
2015	7	25	21	13	24	0.804	-0.095	4.15	0.01	0.007	0	40.9	35.3	76.1	129	113	0	34	31
2015	7	25	21	23	24	0.807	-0.079	4.15	0.013	0.01	0	40.9	35.3	76.5	129	113	0	34	31
2015	7	25	21	33	24	0.823	-0.049	4.15	0.013	0.01	0	42.1	35.7	77	131	115	0	33	32
2015	7	25	21	43	24	0.732	-0.082	4.15	0.01	0.007	0	41.3	36.5	76.1	130	115	0	34	30
2015	7	25	21	53	24	0.755	-0.105	4.15	0.013	0.01	0	41.3	36.1	76.1	130	114	0	34	30
2015	7	25	22	3	24	0.778	-0.108	4.15	0.01	0.007	0	41.3	36.1	76.1	130	115	0	34	31
2015	7	25	22	13	24	0.807	-0.089	4.15	0.013	0.01	0	41.3	36.1	76.5	130	115	0	34	31
2015	7	25	22	23	24	0.764	-0.095	4.154	0.013	0.01	0	41.3	35.7	77.4	130	115	0	34	32
2015	7	25	22	33	24	0.791	-0.098	4.154	0.01	0.007	0	41.7	35.7	77.4	131	115	0	34	32
2015	7	25	22	43	24	0.807	-0.098	4.154	0.013	0.01	0	41.3	36.1	77	130	115	0	34	31
2015	7	25	22	53	24	0.764	-0.089	4.154	0.013	0.01	0	41.3	36.5	77.4	131	116	0	35	31
2015	7	25	23	3	24	0.807	-0.095	4.154	0.01	0.007	0	41.3	35.7	77.4	131	115	0	35	32
2015	7	25	23	13	24	0.781	-0.095	4.154	0.01	0.007	0	41.7	35.7	76.1	130	114	0	33	31
2015	7	25	23	23	24	0.804	-0.082	4.154	0.013	0.01	0	41.3	35.7	74.8	130	114	0	34	31
2015	7	25	23	33	24	0.807	-0.105	4.154	0.01	0.007	0	41.3	35.3	79.1	130	114	0	34	32
2015	7	25	23	43	24	0.784	-0.098	4.154	0.01	0.007	0	41.7	36.1	78.7	131	115	0	34	31
2015	7	25	23	53	24	0.787	-0.112	4.157	0.01	0.007	0	41.3	36.1	79.6	130	115	0	34	31
2015	7	26	0	3	24	0.794	-0.092	4.157	0.01	0.007	0	41.3	36.1	79.1	130	115	0	34	31
2015	7	26	0	13	24	0.787	-0.115	4.157	0.01	0.007	0	41.3	35.7	79.6	130	114	0	34	31
2015	7	26	0	23	24	0.745	-0.075	4.157	0.01	0.007	0	41.3	36.1	79.1	130	115	0	34	31
2015	7	26	0	33	24	0.853	-0.095	4.157	0.016	0.013	0	41.3	35.7	79.1	130	114	0	34	31
2015	7	26	0	43	24	0.771	-0.075	4.157	0.013	0.01	0	41.7	35.3	79.6	130	114	0	33	32
2015	7	26	0	53	24	0.82	-0.095	4.157	0.01	0.007	0	40.9	35.3	80	129	113	0	34	31
2015	7	26	1	3	24	0.804	-0.125	4.157	0.016	0.013	0	40.9	35.7	78.7	129	114	0	34	31
2015	7	26	1	13	24	0.758	-0.072	4.157	0.013	0.01	0	40.9	35.7	79.1	130	114	0	35	31
2015	7	26	1	23	24	0.771	-0.092	4.157	0.01	0.007	0	41.7	35.7	78.7	131	115	0	34	32
2015	7	26	1	33	24	0.791	-0.062	4.157	0.01	0.007	0	41.3	36.1	78.7	131	115	0	35	31
2015	7	26	1	43	24	0.801	-0.075	4.157	0.013	0.01	0	41.3	35.7	78.7	130	114	0	34	31
2015	7	26	1	53	24	0.787	-0.082	4.157	0.016	0.013	0	41.3	35.3	77.8	130	114	0	34	32
2015	7	26	2	3	24	0.801	-0.089	4.157	0.01	0.007	0	41.3	35.3	78.3	130	114	0	34	32
2015	7	26	2	13	24	0.81	-0.092	4.157	0.01	0.007	0	41.3	35.3	78.7	130	114	0	34	32
2015	7	26	2	23	24	0.833	-0.125	4.157	0.013	0.01	0	41.3	35.3	78.7	130	114	0	34	32
2015	7	26	2	33	24	0.771	-0.125	4.157	0.013	0.01	0	41.3	35.3	76.5	130	114	0	34	32
2015	7	26	2	43	24	0.784	-0.112	4.16	0.013	0.01	0	41.3	35.7	78.3	130	115	0	34	32
2015	7	26	2	53	24	0.801	-0.089	4.16	0.01	0.007	0	41.7	35.7	77.8	130	115	0	33	32
2015	7	26	3	3	24	0.768	-0.082	4.16	0.013	0.01	0	41.7	36.1	78.3	131	115	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	26	3	13	24	0.804	-0.095	4.16	0.01	0.007	0	42.1	36.1	77.8	132	116	0	34	32
2015	7	26	3	23	24	0.781	-0.092	4.16	0.01	0.007	0	41.7	36.1	76.1	131	116	0	34	32
2015	7	26	3	33	24	0.81	-0.085	4.16	0.013	0.01	0	41.3	35.7	77.4	130	114	0	34	31
2015	7	26	3	43	24	0.781	-0.082	4.16	0.01	0.007	0	41.3	35.7	77.4	130	115	0	34	32
2015	7	26	3	53	24	0.787	-0.112	4.16	0.013	0.01	0	41.3	35.3	77.8	130	114	0	34	32
2015	7	26	4	3	24	0.801	-0.089	4.16	0.01	0.007	0	41.3	35.3	77.4	130	114	0	34	32
2015	7	26	4	13	24	0.791	-0.079	4.16	0.01	0.007	0	41.7	35.3	76.5	130	114	0	33	32
2015	7	26	4	23	24	0.784	-0.095	4.16	0.01	0.007	0	41.3	35.7	76.1	130	114	0	34	31
2015	7	26	4	33	24	0.83	-0.095	4.16	0.013	0.01	0	41.7	36.1	76.1	130	115	0	33	31
2015	7	26	4	43	24	0.791	-0.098	4.16	0.01	0.007	0	41.3	36.1	76.1	130	115	0	34	31
2015	7	26	4	53	24	0.794	-0.105	4.16	0.01	0.007	0	40.9	36.1	76.5	130	115	0	35	31
2015	7	26	5	3	24	0.814	-0.085	4.16	0.013	0.01	0	41.3	35.7	75.7	130	115	0	34	32
2015	7	26	5	13	24	0.804	-0.092	4.163	0.01	0.007	0	41.7	36.1	76.5	131	115	0	34	31
2015	7	26	5	23	24	0.787	-0.095	4.163	0.01	0.007	0	42.1	36.1	76.1	131	115	0	33	31
2015	7	26	5	33	24	0.781	-0.072	4.163	0.013	0.01	0	41.7	36.5	75.7	131	116	0	34	31
2015	7	26	5	43	24	0.794	-0.105	4.163	0.01	0.007	0	41.7	36.1	74.4	131	115	0	34	31
2015	7	26	5	53	24	0.801	-0.082	4.163	0.01	0.007	0	42.1	35.7	74.8	132	115	0	34	32
2015	7	26	6	3	24	0.784	-0.098	4.163	0.01	0.007	0	42.1	36.1	74.8	132	116	0	34	32
2015	7	26	6	13	24	0.764	-0.102	4.163	0.013	0.01	0	42.1	36.1	74.4	132	116	0	34	32
2015	7	26	6	23	24	0.797	-0.102	4.167	0.01	0.007	0	41.7	36.1	74.4	132	116	0	35	32
2015	7	26	6	33	24	0.771	-0.085	4.167	0.01	0.007	0	42.1	36.1	74.8	132	115	0	34	31
2015	7	26	6	43	24	0.791	-0.089	4.17	0.01	0.007	0	42.1	36.1	74	132	115	0	34	31
2015	7	26	6	53	24	0.784	-0.089	4.173	0.01	0.007	0	42.1	36.1	74.8	132	116	0	34	32
2015	7	26	7	3	24	0.794	-0.082	4.177	0.01	0.007	0	42.1	36.1	75.3	132	116	0	34	32
2015	7	26	7	13	24	0.778	-0.089	4.177	0.013	0.01	0	42.1	35.7	76.1	132	115	0	34	32
2015	7	26	7	23	24	0.83	-0.108	4.177	0.01	0.007	0	41.7	35.7	76.1	131	115	0	34	32
2015	7	26	7	33	24	0.804	-0.102	4.177	0.013	0.01	0	41.7	35.7	76.5	131	115	0	34	32
2015	7	26	7	43	24	0.778	-0.095	4.177	0.01	0.007	0	42.1	35.7	76.1	132	116	0	34	33
2015	7	26	7	53	24	0.81	-0.079	4.177	0.013	0.01	0	42.1	36.1	77	132	116	0	34	32
2015	7	26	8	3	24	0.807	-0.079	4.177	0.01	0.007	0	42.1	36.1	76.1	132	116	0	34	32
2015	7	26	8	13	24	0.774	-0.121	4.177	0.01	0.007	0	41.3	35.7	77	131	115	0	35	32
2015	7	26	8	23	24	0.81	-0.108	4.18	0.016	0.013	0	41.7	35.7	77.8	131	115	0	34	32
2015	7	26	8	33	24	0.794	-0.059	4.18	0.013	0.01	0	41.7	36.5	77.4	132	116	0	35	31
2015	7	26	8	43	24	0.774	-0.095	4.18	0.01	0.007	0	42.1	36.1	77.4	132	115	0	34	31
2015	7	26	8	53	24	0.804	-0.079	4.18	0.01	0.007	0	41.7	35.7	77.8	132	115	0	35	32
2015	7	26	9	3	24	0.787	-0.095	4.18	0.01	0.007	0	41.3	36.1	77.4	131	115	0	35	31
2015	7	26	9	13	24	0.787	-0.079	4.18	0.01	0.007	0	41.7	35.7	77.8	131	115	0	34	32
2015	7	26	9	23	24	0.827	-0.108	4.18	0.013	0.01	0	41.7	36.5	76.1	131	116	0	34	31
2015	7	26	9	33	24	0.817	-0.095	4.18	0.013	0.01	0	42.6	36.5	76.1	133	117	0	34	32
2015	7	26	9	43	24	0.787	-0.095	4.18	0.01	0.007	0	42.1	36.5	77.4	132	116	0	34	31
2015	7	26	9	53	24	0.781	-0.092	4.18	0.016	0.016	0	42.1	36.5	76.5	132	117	0	34	32
2015	7	26	10	3	24	0.764	-0.128	4.18	0.013	0.01	0	42.6	36.5	76.1	133	117	0	34	32
2015	7	26	10	13	24	0.761	-0.098	4.18	0.01	0.007	0	41.7	36.5	76.1	132	116	0	35	31
2015	7	26	10	23	24	0.761	-0.075	4.18	0.016	0.013	0	42.1	36.1	75.3	132	116	0	34	32
2015	7	26	10	33	24	0.771	-0.095	4.18	0.01	0.007	0	41.7	36.5	76.1	132	117	0	35	32
2015	7	26	10	43	24	0.791	-0.082	4.18	0.01	0.007	0	41.7	36.1	75.7	132	116	0	35	32
2015	7	26	10	53	24	0.797	-0.079	4.18	0.016	0.013	0	41.7	36.1	75.3	131	116	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	26	11	3	24	0.787	-0.102	4.18	0.01	0.007	0	41.7	35.7	77	131	115	0	34	32
2015	7	26	11	13	24	0.771	-0.095	4.18	0.01	0.007	0	42.1	36.1	75.3	132	116	0	34	32
2015	7	26	11	23	24	0.768	-0.079	4.18	0.01	0.007	0	42.1	36.5	73.5	132	116	0	34	31
2015	7	26	11	33	24	0.804	-0.102	4.18	0.013	0.01	0	42.6	37	75.3	133	117	0	34	31
2015	7	26	11	43	24	0.787	-0.098	4.177	0.013	0.01	0	42.1	36.5	71	132	117	0	34	32
2015	7	26	11	53	24	0.748	-0.095	4.177	0.01	0.007	0	42.1	37	73.5	132	117	0	34	31
2015	7	26	12	3	24	0.725	-0.105	4.177	0.013	0.01	0	42.1	36.5	72.2	132	117	0	34	32
2015	7	26	12	13	24	0.755	-0.108	4.173	0.01	0.007	0	42.1	36.1	72.7	132	116	0	34	32
2015	7	26	12	23	24	0.764	-0.102	4.17	0.016	0.013	0	42.1	36.5	72.2	132	116	0	34	31
2015	7	26	12	33	24	0.748	-0.112	4.17	0.013	0.01	0	42.1	37	73.1	132	117	0	34	31
2015	7	26	12	43	24	0.761	-0.098	4.167	0.01	0.007	0	42.1	37	65.8	132	117	0	34	31
2015	7	26	12	53	24	0.741	-0.128	4.17	0.016	0.013	0	42.6	37	59.8	133	117	0	34	31
2015	7	26	13	3	24	0.768	-0.102	4.167	0.013	0.01	0	42.6	37	56.3	133	118	0	34	32
2015	7	26	13	13	24	0.751	-0.144	4.167	0.01	0.007	0	42.6	37	49.5	133	117	0	34	31
2015	7	26	13	23	24	0.751	-0.102	4.167	0.01	0.007	0	43	37.4	49.9	134	118	0	34	31
2015	7	26	13	33	24	0.755	-0.079	4.167	0.013	0.01	0	42.6	37.4	51.6	133	118	0	34	31
2015	7	26	13	43	24	0.768	-0.131	4.167	0.013	0.01	0	42.6	37.4	50.7	133	118	0	34	31
2015	7	26	13	53	24	0.764	-0.095	4.163	0.013	0.01	0	42.1	36.5	49	132	117	0	34	32
2015	7	26	14	3	24	0.751	-0.066	4.163	0.016	0.013	0	42.1	37	55.5	132	117	0	34	31
2015	7	26	14	13	24	0.738	-0.105	4.163	0.01	0.007	0	42.6	36.5	50.3	133	117	0	34	32
2015	7	26	14	23	24	0.768	-0.112	4.163	0.01	0.007	0	42.1	36.1	48.2	132	116	0	34	32
2015	7	26	14	33	24	0.719	-0.118	4.163	0.01	0.007	0	42.1	36.1	55	132	116	0	34	32
2015	7	26	14	43	24	0.745	-0.092	4.163	0.01	0.007	0	42.1	36.1	54.6	132	116	0	34	32
2015	7	26	14	53	24	0.728	-0.118	4.16	0.013	0.01	0	42.1	36.5	48.6	132	116	0	34	31
2015	7	26	15	3	24	0.761	-0.075	4.16	0.01	0.007	0	42.1	36.1	54.2	132	116	0	34	32
2015	7	26	15	13	24	0.692	-0.089	4.157	0.013	0.01	0	49	38.3	43	148	121	0	34	32
2015	7	26	15	23	24	0.827	-0.102	4.157	0.013	0.01	0	45.2	38.7	49.5	139	121	0	34	31
2015	7	26	15	33	24	0.778	-0.079	4.16	0.013	0.01	0	42.6	36.5	45.2	133	117	0	34	32
2015	7	26	15	43	24	0.745	-0.069	4.16	0.01	0.007	0	42.1	36.1	56.8	132	116	0	34	32
2015	7	26	15	53	24	0.764	-0.062	4.157	0.016	0.013	0	42.6	37	54.6	133	117	0	34	31
2015	7	26	16	3	24	0.755	-0.102	4.157	0.01	0.007	0	42.6	36.5	55.9	133	117	0	34	32
2015	7	26	16	13	24	0.755	-0.108	4.157	0.01	0.007	0	42.6	37	57.2	134	118	0	35	32
2015	7	26	16	23	24	0.738	-0.095	4.157	0.01	0.007	0	42.1	37	59.3	132	117	0	34	31
2015	7	26	16	33	24	0.758	-0.105	4.157	0.01	0.007	0	42.6	37	59.3	133	117	0	34	31
2015	7	26	16	43	24	0.787	-0.115	4.157	0.013	0.01	0	42.1	36.5	66.2	132	116	0	34	31
2015	7	26	16	53	24	0.774	-0.075	4.157	0.01	0.007	0	42.1	36.5	64.1	132	116	0	34	31
2015	7	26	17	3	24	0.761	-0.082	4.157	0.01	0.007	0	42.6	36.5	67.9	133	116	0	34	31
2015	7	26	17	13	24	0.738	-0.138	4.157	0.01	0.007	0	42.6	37	64.9	133	117	0	34	31
2015	7	26	17	23	24	0.771	-0.085	4.154	0.01	0.007	0	43	37	57.2	134	117	0	34	31
2015	7	26	17	33	24	0.81	-0.075	4.154	0.01	0.007	0	42.1	36.5	61.9	132	116	0	34	31
2015	7	26	17	43	24	0.817	-0.069	4.147	0.013	0.01	0	46.9	40.4	42.6	143	126	0	34	32
2015	7	26	17	53	24	0.879	-0.049	4.147	0.01	0.007	0	51.6	46.4	39.6	154	139	0	34	31
2015	7	26	18	3	24	0.751	-0.092	4.147	0.013	0.01	0	51.2	45.6	42.6	153	138	0	34	32
2015	7	26	18	13	24	0.794	-0.095	4.144	0.013	0.01	0	49.9	44.3	44.3	150	134	0	34	31
2015	7	26	18	23	24	0.81	-0.046	4.147	0.01	0.007	0	45.6	39.6	48.6	140	123	0	34	31
2015	7	26	18	33	24	0.869	-0.079	4.144	0.01	0.007	0	46.4	40.9	49	142	126	0	34	31
2015	7	26	18	43	24	0.823	-0.115	4.147	0.01	0.007	0	42.6	37.4	55	133	118	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	26	18	53	24	0.853	-0.079	4.147	0.01	0.007	0	42.6	36.5	55.5	132	116	0	33	31
2015	7	26	19	3	24	0.804	-0.092	4.144	0.016	0.013	0	43.4	37.4	50.3	135	118	0	34	31
2015	7	26	19	13	24	0.787	-0.079	4.147	0.01	0.007	0	42.6	36.5	54.2	133	117	0	34	32
2015	7	26	19	23	24	0.801	-0.092	4.144	0.01	0.007	0	42.6	36.5	51.6	133	116	0	34	31
2015	7	26	19	33	24	0.784	-0.069	4.144	0.01	0.007	0	46.9	39.1	43.9	143	123	0	34	32
2015	7	26	19	43	24	0.791	-0.082	4.144	0.01	0.007	0	46	40	46.4	141	125	0	34	32
2015	7	26	19	53	24	0.853	-0.072	4.144	0.01	0.007	0	46.4	40.9	46	142	126	0	34	31
2015	7	26	20	3	24	0.797	-0.082	4.144	0.01	0.007	0	45.2	40.4	44.7	140	125	0	35	31
2015	7	26	20	13	24	0.846	-0.062	4.14	0.01	0.007	0	45.6	38.3	46	140	120	0	34	31
2015	7	26	20	23	24	0.837	-0.082	4.137	0.01	0.007	0	46	40.4	43.9	141	125	0	34	31
2015	7	26	20	33	24	0.827	-0.102	4.15	0.01	0.007	0	42.1	36.5	75.3	132	116	0	34	31
2015	7	26	20	43	24	0.804	-0.095	4.15	0.013	0.01	0	42.1	36.1	75.3	132	116	0	34	32
2015	7	26	20	53	24	0.804	-0.085	4.15	0.01	0.007	0	42.6	36.5	75.3	133	116	0	34	31
2015	7	26	21	3	24	0.781	-0.112	4.15	0.013	0.01	0	42.6	37	75.7	133	117	0	34	31
2015	7	26	21	13	24	0.784	-0.069	4.15	0.01	0.007	0	42.1	37	75.7	132	117	0	34	31
2015	7	26	21	23	24	0.778	-0.069	4.15	0.013	0.01	0	43	36.5	73.5	133	116	0	33	31
2015	7	26	21	33	24	0.791	-0.131	4.15	0.01	0.007	0	42.1	36.5	75.3	132	116	0	34	31
2015	7	26	21	43	24	0.807	-0.098	4.147	0.01	0.007	0	42.1	36.1	72.2	132	116	0	34	32
2015	7	26	21	53	24	0.774	-0.082	4.147	0.013	0.01	0	42.1	36.1	74	132	115	0	34	31
2015	7	26	22	3	24	0.797	-0.089	4.147	0.013	0.01	0	42.1	36.1	71.8	132	116	0	34	32
2015	7	26	22	13	24	0.751	-0.095	4.147	0.01	0.007	0	42.1	36.5	66.2	132	116	0	34	31
2015	7	26	22	23	24	0.778	-0.092	4.144	0.01	0.007	0	42.1	36.1	62.4	132	116	0	34	32
2015	7	26	22	33	24	0.768	-0.135	4.147	0.013	0.01	0	42.1	36.5	74.4	132	116	0	34	31
2015	7	26	22	43	24	0.804	-0.112	4.147	0.013	0.01	0	42.6	36.1	75.3	133	116	0	34	32
2015	7	26	22	53	24	0.82	-0.098	4.147	0.01	0.007	0	42.1	36.1	75.3	132	116	0	34	32
2015	7	26	23	3	24	0.791	-0.089	4.147	0.013	0.01	0	42.6	36.5	75.7	133	116	0	34	31
2015	7	26	23	13	24	0.787	-0.089	4.147	0.01	0.007	0	42.6	37	75.7	133	117	0	34	31
2015	7	26	23	23	24	0.787	-0.079	4.147	0.01	0.007	0	42.6	36.5	75.7	133	117	0	34	32
2015	7	26	23	33	24	0.748	-0.079	4.147	0.01	0.007	0	43	37	75.3	133	117	0	33	31
2015	7	26	23	43	24	0.814	-0.066	4.147	0.01	0.007	0	42.6	36.5	75.7	133	116	0	34	31
2015	7	26	23	53	24	0.801	-0.112	4.147	0.01	0.007	0	42.6	36.5	76.1	133	116	0	34	31
2015	7	27	0	3	24	0.768	-0.098	4.147	0.01	0.007	0	42.6	36.5	75.3	133	117	0	34	32
2015	7	27	0	13	24	0.771	-0.092	4.147	0.01	0.007	0	42.6	36.5	75.3	132	116	0	33	31
2015	7	27	0	23	24	0.781	-0.072	4.147	0.013	0.01	0	42.1	36.5	75.7	133	117	0	35	32
2015	7	27	0	33	24	0.794	-0.092	4.147	0.01	0.007	0	42.1	36.5	75.3	132	116	0	34	31
2015	7	27	0	43	24	0.801	-0.085	4.147	0.01	0.007	0	42.1	36.1	75.7	132	116	0	34	32
2015	7	27	0	53	24	0.758	-0.098	4.147	0.013	0.01	0	42.6	36.5	76.1	133	116	0	34	31
2015	7	27	1	3	24	0.764	-0.089	4.147	0.01	0.007	0	41.7	35.7	75.7	132	115	0	35	32
2015	7	27	1	13	24	0.787	-0.069	4.147	0.01	0.007	0	41.7	36.1	76.5	132	116	0	35	32
2015	7	27	1	23	24	0.778	-0.092	4.147	0.01	0.007	0	42.1	36.5	76.1	132	116	0	34	31
2015	7	27	1	33	24	0.778	-0.079	4.147	0.01	0.007	0	42.1	35.7	76.5	132	115	0	34	32
2015	7	27	1	43	24	0.771	-0.082	4.147	0.01	0.007	0	42.1	35.7	75.7	132	115	0	34	32
2015	7	27	1	53	24	0.804	-0.095	4.147	0.01	0.007	0	41.7	36.1	76.1	131	115	0	34	31
2015	7	27	2	3	24	0.81	-0.069	4.147	0.01	0.007	0	41.7	36.1	75.7	131	115	0	34	31
2015	7	27	2	13	24	0.787	-0.079	4.147	0.013	0.01	0	41.7	35.7	74.4	131	115	0	34	32
2015	7	27	2	23	24	0.81	-0.075	4.147	0.013	0.01	0	41.7	35.7	76.5	131	115	0	34	32
2015	7	27	2	33	24	0.794	-0.085	4.147	0.01	0.007	0	41.7	35.3	76.5	131	114	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	27	2	43	24	0.814	-0.095	4.147	0.013	0.01	0	41.7	36.1	76.5	131	115	0	34	31
2015	7	27	2	53	24	0.774	-0.098	4.147	0.01	0.007	0	41.7	36.1	76.5	131	115	0	34	31
2015	7	27	3	3	24	0.781	-0.098	4.147	0.01	0.007	0	42.1	36.1	76.5	132	115	0	34	31
2015	7	27	3	13	24	0.797	-0.102	4.147	0.01	0.007	0	41.7	35.3	76.5	131	114	0	34	32
2015	7	27	3	23	24	0.758	-0.079	4.147	0.01	0.007	0	41.7	35.7	77.4	131	115	0	34	32
2015	7	27	3	33	24	0.787	-0.095	4.147	0.01	0.007	0	42.1	36.1	77.4	132	115	0	34	31
2015	7	27	3	43	24	0.784	-0.112	4.147	0.01	0.007	0	41.7	35.7	75.3	131	115	0	34	32
2015	7	27	3	53	24	0.81	-0.085	4.144	0.01	0.007	0	42.1	36.1	73.1	132	116	0	34	32
2015	7	27	4	3	24	0.794	-0.079	4.144	0.01	0.007	0	42.1	36.5	71	133	116	0	35	31
2015	7	27	4	13	24	0.787	-0.102	4.144	0.01	0.007	0	42.1	36.5	71	132	116	0	34	31
2015	7	27	4	23	24	0.801	-0.062	4.144	0.01	0.007	0	42.1	36.1	69.2	133	116	0	35	32
2015	7	27	4	33	24	0.794	-0.079	4.144	0.013	0.01	0	42.6	37	74.4	133	117	0	34	31
2015	7	27	4	43	24	0.768	-0.046	4.144	0.016	0.013	0	42.1	36.1	76.1	133	117	0	35	33
2015	7	27	4	53	24	0.761	-0.098	4.147	0.013	0.01	0	42.6	36.1	77.4	133	116	0	34	32
2015	7	27	5	3	24	0.791	-0.095	4.144	0.01	0.007	0	42.1	36.5	76.5	133	117	0	35	32
2015	7	27	5	13	24	0.787	-0.085	4.144	0.016	0.013	0	42.6	36.5	77	133	117	0	34	32
2015	7	27	5	23	24	0.761	-0.105	4.144	0.01	0.007	0	43	37.4	76.5	134	118	0	34	31
2015	7	27	5	33	24	0.823	-0.095	4.144	0.01	0.007	0	43	37.4	77.4	134	118	0	34	31
2015	7	27	5	43	24	0.833	-0.066	4.144	0.01	0.007	0	43	37.4	77.4	134	118	0	34	31
2015	7	27	5	53	24	0.797	-0.108	4.144	0.013	0.01	0	42.6	36.5	76.1	133	116	0	34	31
2015	7	27	6	3	24	0.801	-0.079	4.144	0.01	0.007	0	42.6	36.5	77.4	133	117	0	34	32
2015	7	27	6	13	24	0.791	-0.115	4.144	0.01	0.007	0	41.7	36.5	77	132	116	0	35	31
2015	7	27	6	23	24	0.761	-0.043	4.144	0.01	0.007	0	42.6	36.5	77	133	116	0	34	31
2015	7	27	6	33	24	0.778	-0.079	4.144	0.01	0.007	0	42.6	36.5	76.5	133	117	0	34	32
2015	7	27	6	43	24	0.791	-0.112	4.144	0.013	0.01	0	42.6	35.7	77	132	115	0	33	32
2015	7	27	6	53	24	0.794	-0.115	4.144	0.013	0.01	0	41.7	35.7	74.8	131	115	0	34	32
2015	7	27	7	3	24	0.758	-0.118	4.144	0.013	0.01	0	42.1	36.1	75.7	132	116	0	34	32
2015	7	27	7	13	24	0.807	-0.082	4.144	0.01	0.007	0	42.1	36.1	77	132	115	0	34	31
2015	7	27	7	23	24	0.817	-0.105	4.144	0.01	0.007	0	42.1	36.5	74.4	132	116	0	34	31
2015	7	27	7	33	24	0.784	-0.082	4.144	0.01	0.007	0	42.6	36.5	77	133	117	0	34	32
2015	7	27	7	43	24	0.791	-0.085	4.144	0.01	0.007	0	42.1	36.1	76.5	132	116	0	34	32
2015	7	27	7	53	24	0.833	-0.095	4.144	0.013	0.01	0	41.7	35.7	76.1	131	115	0	34	32
2015	7	27	8	3	24	0.787	-0.079	4.144	0.01	0.007	0	42.1	36.1	71.8	132	115	0	34	31
2015	7	27	8	13	24	0.794	-0.079	4.144	0.01	0.007	0	42.6	36.1	65.8	133	116	0	34	32
2015	7	27	8	23	24	0.781	-0.095	4.144	0.01	0.007	0	41.7	36.1	59.3	132	116	0	35	32
2015	7	27	8	33	24	0.761	-0.098	4.14	0.01	0.007	0	44.7	38.7	64.1	138	122	0	34	32
2015	7	27	8	43	24	0.774	-0.095	4.14	0.01	0.007	0	45.2	39.1	54.6	139	123	0	34	32
2015	7	27	8	53	24	0.787	-0.092	4.14	0.01	0.007	0	45.2	38.7	58.9	139	122	0	34	32
2015	7	27	9	3	24	0.738	-0.085	4.14	0.01	0.007	0	43.4	38.3	67.1	136	120	0	35	31
2015	7	27	9	13	24	0.758	-0.075	4.14	0.01	0.007	0	43	37.8	65.4	134	119	0	34	31
2015	7	27	9	23	24	0.725	-0.082	4.14	0.01	0.007	0	43	37	63.2	134	118	0	34	32
2015	7	27	9	33	24	0.794	-0.079	4.14	0.01	0.007	0	42.6	37	62.4	134	118	0	35	32
2015	7	27	9	43	24	0.781	-0.079	4.14	0.01	0.007	0	42.6	37	72.7	133	117	0	34	31
2015	7	27	9	53	24	0.778	-0.079	4.14	0.01	0.007	0	42.6	36.5	74	133	117	0	34	32
2015	7	27	10	3	24	0.771	-0.095	4.14	0.01	0.007	0	42.6	36.5	75.7	133	117	0	34	32
2015	7	27	10	13	24	0.778	-0.105	4.14	0.013	0.01	0	42.1	36.1	75.3	132	116	0	34	32
2015	7	27	10	23	24	0.787	-0.095	4.14	0.016	0.013	0	41.7	36.1	72.7	132	116	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	27	10	33	24	0.771	-0.085	4.14	0.01	0.007	0	42.1	36.1	73.5	132	116	0	34	32
2015	7	27	10	43	24	0.768	-0.072	4.137	0.01	0.007	0	42.1	37	74.8	132	117	0	34	31
2015	7	27	10	53	24	0.771	-0.102	4.137	0.01	0.007	0	41.3	36.1	74.4	131	116	0	35	32
2015	7	27	11	3	24	0.751	-0.082	4.137	0.01	0.007	0	41.7	36.5	74.4	131	116	0	34	31
2015	7	27	11	13	24	0.755	-0.069	4.137	0.01	0.007	0	41.7	36.1	73.5	131	115	0	34	31
2015	7	27	11	23	24	0.804	-0.079	4.134	0.01	0.007	0	42.1	36.5	74	132	116	0	34	31
2015	7	27	11	33	24	0.794	-0.105	4.134	0.01	0.007	0	42.1	36.1	73.5	132	116	0	34	32
2015	7	27	11	43	24	0.771	-0.102	4.131	0.01	0.007	0	41.7	36.5	73.5	132	116	0	35	31
2015	7	27	11	53	24	0.755	-0.049	4.127	0.01	0.007	0	42.1	36.5	73.5	132	116	0	34	31
2015	7	27	12	3	24	0.761	-0.089	4.124	0.01	0.007	0	41.7	36.1	74	132	116	0	35	32
2015	7	27	12	13	24	0.81	-0.075	4.124	0.01	0.007	0	41.7	36.1	74.4	131	115	0	34	31
2015	7	27	12	23	24	0.781	-0.102	4.124	0.01	0.007	0	41.3	36.1	74.8	131	116	0	35	32
2015	7	27	12	33	24	0.761	-0.059	4.124	0.01	0.007	0	42.1	36.5	74.8	132	116	0	34	31
2015	7	27	12	43	24	0.787	-0.062	4.124	0.01	0.007	0	41.7	36.1	75.3	132	116	0	35	32
2015	7	27	12	53	24	0.791	-0.082	4.124	0.01	0.007	0	42.1	36.5	76.1	132	116	0	34	31
2015	7	27	13	3	24	0.764	-0.098	4.124	0.01	0.007	0	42.1	36.1	75.3	132	116	0	34	32
2015	7	27	13	13	24	0.758	-0.105	4.124	0.016	0.016	0	41.7	36.1	74.8	131	116	0	34	32
2015	7	27	13	23	24	0.791	-0.072	4.121	0.01	0.007	0	41.7	36.1	75.7	132	116	0	35	32
2015	7	27	13	33	24	0.791	-0.046	4.121	0.01	0.007	0	41.7	36.5	76.5	132	116	0	35	31
2015	7	27	13	43	24	0.807	-0.082	4.121	0.01	0.007	0	41.7	36.1	75.3	131	115	0	34	31
2015	7	27	13	53	24	0.764	-0.079	4.121	0.013	0.01	0	42.6	36.5	76.5	133	117	0	34	32
2015	7	27	14	3	24	0.778	-0.079	4.121	0.01	0.007	0	41.7	36.5	77.4	132	116	0	35	31
2015	7	27	14	13	24	0.768	-0.082	4.121	0.013	0.01	0	42.1	36.1	77	132	116	0	34	32
2015	7	27	14	23	24	0.748	-0.095	4.121	0.01	0.007	0	42.6	36.1	77	132	115	0	33	31
2015	7	27	14	33	24	0.814	-0.082	4.121	0.013	0.01	0	42.1	36.5	77.8	132	116	0	34	31
2015	7	27	14	43	24	0.768	-0.069	4.121	0.01	0.007	0	41.7	35.7	77.4	131	115	0	34	32
2015	7	27	14	53	24	0.771	-0.108	4.117	0.01	0.007	0	41.3	35.7	77	130	114	0	34	31
2015	7	27	15	3	24	0.768	-0.082	4.117	0.01	0.007	0	41.7	35.7	77.8	131	115	0	34	32
2015	7	27	15	13	24	0.755	-0.102	4.117	0.01	0.007	0	41.3	35.3	76.1	130	114	0	34	32
2015	7	27	15	23	24	0.817	-0.092	4.117	0.01	0.007	0	41.7	35.3	76.5	131	114	0	34	32
2015	7	27	15	33	24	0.814	-0.095	4.117	0.01	0.007	0	41.3	35.7	72.2	130	114	0	34	31
2015	7	27	15	43	24	0.774	-0.121	4.117	0.013	0.01	0	41.3	35.3	75.3	130	114	0	34	32
2015	7	27	15	53	24	0.755	-0.072	4.117	0.01	0.007	0	41.3	35.3	77.8	130	113	0	34	31
2015	7	27	16	3	24	0.784	-0.079	4.114	0.01	0.007	0	41.3	34.8	66.7	130	113	0	34	32
2015	7	27	16	13	24	0.801	-0.118	4.117	0.013	0.01	0	41.3	35.3	77.4	130	113	0	34	31
2015	7	27	16	23	24	0.781	-0.095	4.117	0.01	0.007	0	41.3	35.3	78.3	130	114	0	34	32
2015	7	27	16	33	24	0.787	-0.112	4.117	0.01	0.007	0	41.3	35.3	78.3	130	114	0	34	32
2015	7	27	16	43	24	0.778	-0.066	4.117	0.01	0.007	0	41.3	35.3	77.8	130	114	0	34	32
2015	7	27	16	53	24	0.768	-0.105	4.117	0.01	0.007	0	41.3	35.7	78.3	130	114	0	34	31
2015	7	27	17	3	24	0.778	-0.085	4.117	0.01	0.007	0	41.3	35.3	77.4	130	114	0	34	32
2015	7	27	17	13	24	0.804	-0.108	4.117	0.01	0.007	0	41.7	35.7	77.4	131	114	0	34	31
2015	7	27	17	23	24	0.801	-0.092	4.117	0.01	0.007	0	41.3	35.3	78.3	130	114	0	34	32
2015	7	27	17	33	24	0.778	-0.085	4.114	0.013	0.01	0	41.3	35.3	78.3	130	114	0	34	32
2015	7	27	17	43	24	0.732	-0.082	4.114	0.01	0.007	0	41.3	35.3	77.4	130	114	0	34	32
2015	7	27	17	53	24	0.807	-0.112	4.114	0.013	0.01	0	40.9	35.7	77.4	130	114	0	35	31
2015	7	27	18	3	24	0.781	-0.062	4.114	0.01	0.007	0	41.3	35.3	77.8	130	114	0	34	32
2015	7	27	18	13	24	0.804	-0.102	4.114	0.01	0.007	0	41.3	34.8	77.4	130	113	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	27	18	23	24	0.774	-0.112	4.114	0.013	0.01	0	41.3	35.3	77.4	130	113	0	34	31
2015	7	27	18	33	24	0.764	-0.095	4.114	0.01	0.007	0	41.3	35.3	77.4	130	114	0	34	32
2015	7	27	18	43	24	0.801	-0.108	4.114	0.01	0.007	0	41.3	35.7	78.3	130	114	0	34	31
2015	7	27	18	53	24	0.827	-0.095	4.114	0.01	0.007	0	41.3	35.3	78.3	130	114	0	34	32
2015	7	27	19	3	24	0.778	-0.085	4.114	0.01	0.007	0	41.3	34.8	77	130	113	0	34	32
2015	7	27	19	13	24	0.794	-0.085	4.114	0.01	0.007	0	41.7	35.7	77.8	131	114	0	34	31
2015	7	27	19	23	24	0.82	-0.079	4.114	0.01	0.007	0	41.7	36.1	77.4	131	115	0	34	31
2015	7	27	19	33	24	0.794	-0.079	4.114	0.01	0.007	0	41.7	35.3	77.4	131	114	0	34	32
2015	7	27	19	43	24	0.801	-0.085	4.114	0.016	0.013	0	41.3	35.7	77.4	130	114	0	34	31
2015	7	27	19	53	24	0.784	-0.095	4.117	0.01	0.007	0	41.7	36.1	77.4	131	115	0	34	31
2015	7	27	20	3	24	0.801	-0.089	4.114	0.01	0.007	0	42.1	36.5	78.3	132	116	0	34	31
2015	7	27	20	13	24	0.791	-0.089	4.117	0.01	0.007	0	42.1	36.1	77.4	133	116	0	35	32
2015	7	27	20	23	24	0.801	-0.098	4.117	0.01	0.007	0	43	36.5	77.8	133	116	0	33	31
2015	7	27	20	33	24	0.771	-0.072	4.117	0.01	0.007	0	42.6	37	76.1	133	117	0	34	31
2015	7	27	20	43	24	0.784	-0.112	4.117	0.01	0.007	0	42.6	36.5	77	133	117	0	34	32
2015	7	27	20	53	24	0.761	-0.066	4.117	0.013	0.01	0	42.1	36.5	75.3	132	116	0	34	31
2015	7	27	21	3	24	0.764	-0.089	4.117	0.01	0.007	0	42.1	36.1	76.5	132	116	0	34	32
2015	7	27	21	13	24	0.791	-0.082	4.117	0.016	0.013	0	42.1	36.1	77.4	132	116	0	34	32
2015	7	27	21	23	24	0.764	-0.112	4.117	0.01	0.007	0	42.1	36.5	77	132	116	0	34	31
2015	7	27	21	33	24	0.817	-0.118	4.117	0.01	0.007	0	42.1	36.1	77	132	116	0	34	32
2015	7	27	21	43	24	0.764	-0.128	4.117	0.01	0.007	0	42.6	36.5	76.5	133	116	0	34	31
2015	7	27	21	53	24	0.784	-0.092	4.117	0.013	0.01	0	42.6	35.7	77	132	115	0	33	32
2015	7	27	22	3	24	0.797	-0.089	4.117	0.01	0.007	0	42.1	36.1	76.5	132	116	0	34	32
2015	7	27	22	13	24	0.745	-0.098	4.117	0.013	0.01	0	42.1	36.1	76.5	132	115	0	34	31
2015	7	27	22	23	24	0.817	-0.046	4.117	0.013	0.01	0	42.1	36.1	76.1	132	116	0	34	32
2015	7	27	22	33	24	0.801	-0.059	4.117	0.013	0.01	0	42.1	36.1	77	131	115	0	33	31
2015	7	27	22	43	24	0.804	-0.102	4.117	0.01	0.007	0	42.1	36.1	77	132	115	0	34	31
2015	7	27	22	53	24	0.784	-0.098	4.117	0.013	0.01	0	42.1	36.1	76.1	132	115	0	34	31
2015	7	27	23	3	24	0.787	-0.098	4.121	0.016	0.013	0	42.1	35.7	76.5	132	115	0	34	32
2015	7	27	23	13	24	0.771	-0.092	4.121	0.01	0.007	0	42.1	36.1	75.7	131	115	0	33	31
2015	7	27	23	23	24	0.751	-0.098	4.121	0.01	0.007	0	42.6	36.5	74.4	133	116	0	34	31
2015	7	27	23	33	24	0.781	-0.105	4.121	0.01	0.007	0	42.1	36.5	76.1	132	116	0	34	31
2015	7	27	23	43	24	0.797	-0.069	4.121	0.01	0.007	0	42.1	36.1	76.1	132	116	0	34	32
2015	7	27	23	53	24	0.784	-0.089	4.121	0.013	0.01	0	41.7	36.1	75.7	132	115	0	35	31
2015	7	28	0	3	24	0.758	-0.112	4.121	0.01	0.007	0	42.6	36.5	75.3	133	116	0	34	31
2015	7	28	0	13	24	0.807	-0.095	4.124	0.01	0.007	0	41.3	35.7	74.8	131	115	0	35	32
2015	7	28	0	23	24	0.794	-0.069	4.124	0.01	0.007	0	41.3	35.7	75.3	131	115	0	35	32
2015	7	28	0	33	24	0.814	-0.092	4.124	0.013	0.01	0	41.7	36.1	74.4	132	115	0	35	31
2015	7	28	0	43	24	0.794	-0.128	4.124	0.01	0.007	0	41.7	35.7	74.8	131	115	0	34	32
2015	7	28	0	53	24	0.81	-0.079	4.124	0.01	0.007	0	41.7	36.1	74	131	115	0	34	31
2015	7	28	1	3	24	0.82	-0.095	4.124	0.01	0.007	0	42.1	36.1	74	132	115	0	34	31
2015	7	28	1	13	24	0.807	-0.062	4.124	0.01	0.007	0	42.1	36.1	73.1	132	116	0	34	32
2015	7	28	1	23	24	0.81	-0.118	4.127	0.01	0.007	0	42.1	35.7	72.7	132	115	0	34	32
2015	7	28	1	33	24	0.781	-0.075	4.131	0.01	0.007	0	41.7	35.7	73.1	132	115	0	35	32
2015	7	28	1	43	24	0.761	-0.082	4.134	0.01	0.007	0	42.6	36.5	73.1	132	116	0	33	31
2015	7	28	1	53	24	0.797	-0.082	4.137	0.01	0.007	0	42.1	35.7	73.5	132	115	0	34	32
2015	7	28	2	3	24	0.781	-0.128	4.137	0.01	0.007	0	41.7	36.1	74.4	131	115	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	28	2	13	24	0.784	-0.072	4.14	0.01	0.007	0	42.1	36.5	74.4	132	116	0	34	31
2015	7	28	2	23	24	0.807	-0.105	4.14	0.01	0.007	0	42.1	36.5	74.4	132	116	0	34	31
2015	7	28	2	33	24	0.81	-0.092	4.14	0.01	0.007	0	41.7	36.1	75.3	132	116	0	35	32
2015	7	28	2	43	24	0.774	-0.105	4.14	0.01	0.007	0	41.7	36.1	75.7	131	115	0	34	31
2015	7	28	2	53	24	0.774	-0.082	4.144	0.01	0.007	0	41.7	36.1	75.7	132	115	0	35	31
2015	7	28	3	3	24	0.778	-0.092	4.144	0.013	0.01	0	41.7	36.1	74	131	115	0	34	31
2015	7	28	3	13	24	0.784	-0.112	4.144	0.013	0.01	0	42.1	35.3	76.5	132	115	0	34	33
2015	7	28	3	23	24	0.768	-0.095	4.144	0.01	0.007	0	42.1	35.7	77.8	132	115	0	34	32
2015	7	28	3	33	24	0.761	-0.085	4.144	0.01	0.007	0	41.3	35.7	77.4	131	115	0	35	32
2015	7	28	3	43	24	0.807	-0.095	4.147	0.013	0.01	0	42.1	35.7	76.5	132	115	0	34	32
2015	7	28	3	53	24	0.797	-0.102	4.147	0.01	0.007	0	41.7	35.7	77.4	132	115	0	35	32
2015	7	28	4	3	24	0.801	-0.089	4.147	0.01	0.007	0	41.7	36.1	77	131	115	0	34	31
2015	7	28	4	13	24	0.801	-0.082	4.147	0.01	0.007	0	42.1	36.5	76.5	132	116	0	34	31
2015	7	28	4	23	24	0.801	-0.082	4.147	0.013	0.01	0	41.7	36.1	76.1	132	116	0	35	32
2015	7	28	4	33	24	0.804	-0.075	4.147	0.01	0.007	0	41.7	35.7	77	131	115	0	34	32
2015	7	28	4	43	24	0.814	-0.108	4.147	0.013	0.01	0	42.1	35.7	76.1	132	115	0	34	32
2015	7	28	4	53	24	0.787	-0.079	4.147	0.016	0.013	0	41.7	36.1	76.1	132	115	0	35	31
2015	7	28	5	3	24	0.794	-0.079	4.147	0.01	0.007	0	42.1	35.7	77	132	115	0	34	32
2015	7	28	5	13	24	0.807	-0.089	4.147	0.01	0.007	0	41.7	36.1	76.5	132	115	0	35	31
2015	7	28	5	23	24	0.768	-0.082	4.147	0.016	0.013	0	42.1	35.7	77	132	115	0	34	32
2015	7	28	5	33	24	0.755	-0.069	4.147	0.01	0.007	0	42.1	36.1	76.1	132	116	0	34	32
2015	7	28	5	43	24	0.774	-0.095	4.147	0.01	0.007	0	42.1	35.7	76.5	132	115	0	34	32
2015	7	28	5	53	24	0.787	-0.085	4.15	0.01	0.007	0	42.1	35.7	75.3	132	116	0	34	33
2015	7	28	6	3	24	0.794	-0.072	4.147	0.01	0.007	0	42.1	36.1	76.1	133	116	0	35	32
2015	7	28	6	13	24	0.807	-0.095	4.15	0.01	0.007	0	42.1	37	76.5	133	117	0	35	31
2015	7	28	6	23	24	0.784	-0.095	4.15	0.01	0.007	0	42.1	36.1	76.5	133	116	0	35	32
2015	7	28	6	33	24	0.83	-0.069	4.15	0.013	0.01	0	42.1	36.1	76.1	132	115	0	34	31
2015	7	28	6	43	24	0.804	-0.089	4.15	0.01	0.007	0	41.3	35.7	75.7	131	115	0	35	32
2015	7	28	6	53	24	0.791	-0.079	4.15	0.01	0.007	0	41.7	35.7	75.7	132	115	0	35	32
2015	7	28	7	3	24	0.778	-0.098	4.15	0.01	0.007	0	42.1	36.1	75.7	132	116	0	34	32
2015	7	28	7	13	24	0.801	-0.098	4.15	0.013	0.01	0	41.3	35.3	75.7	131	114	0	35	32
2015	7	28	7	23	24	0.804	-0.098	4.15	0.01	0.007	0	41.3	35.3	75.7	131	114	0	35	32
2015	7	28	7	33	24	0.82	-0.118	4.154	0.01	0.007	0	41.7	36.1	75.3	131	115	0	34	31
2015	7	28	7	43	24	0.794	-0.095	4.154	0.01	0.007	0	41.3	35.3	74.4	131	115	0	35	33
2015	7	28	7	53	24	0.807	-0.102	4.15	0.01	0.007	0	41.3	35.7	73.1	131	115	0	35	32
2015	7	28	8	3	24	0.82	-0.115	4.154	0.01	0.007	0	41.7	35.7	73.5	131	115	0	34	32
2015	7	28	8	13	24	0.787	-0.085	4.154	0.01	0.007	0	41.3	35.7	74	130	115	0	34	32
2015	7	28	8	23	24	0.781	-0.079	4.154	0.013	0.01	0	41.7	36.1	74.4	131	115	0	34	31
2015	7	28	8	33	24	0.814	-0.095	4.154	0.01	0.007	0	41.3	36.1	74	131	115	0	35	31
2015	7	28	8	43	24	0.784	-0.089	4.154	0.01	0.007	0	42.1	35.7	72.7	132	115	0	34	32
2015	7	28	8	53	24	0.755	-0.095	4.154	0.013	0.01	0	41.7	35.7	73.1	132	115	0	35	32
2015	7	28	9	3	24	0.771	-0.095	4.154	0.01	0.007	0	42.6	36.5	70.5	133	116	0	34	31
2015	7	28	9	13	24	0.791	-0.079	4.154	0.013	0.01	0	43.4	37.4	59.8	135	118	0	34	31
2015	7	28	9	23	24	0.814	-0.069	4.154	0.01	0.007	0	43.4	37	61.1	135	118	0	34	32
2015	7	28	9	33	24	0.778	-0.082	4.154	0.01	0.007	0	43	37.4	72.2	134	118	0	34	31
2015	7	28	9	43	24	0.804	-0.125	4.154	0.016	0.013	0	43	37	69.2	134	118	0	34	32
2015	7	28	9	53	24	0.791	-0.085	4.154	0.016	0.013	0	43	37	64.9	134	118	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	28	10	3	24	0.735	-0.056	4.154	0.01	0.007	0	42.6	37	68.8	133	118	0	34	32
2015	7	28	10	13	24	0.755	-0.095	4.154	0.01	0.007	0	43	37	73.5	134	118	0	34	32
2015	7	28	10	23	24	0.801	-0.062	4.154	0.01	0.007	0	41.7	37	70.1	132	117	0	35	31
2015	7	28	10	33	24	0.741	-0.082	4.154	0.016	0.013	0	42.6	36.5	72.7	133	117	0	34	32
2015	7	28	10	43	24	0.758	-0.102	4.154	0.01	0.007	0	42.1	37	74.4	132	117	0	34	31
2015	7	28	10	53	24	0.761	-0.072	4.154	0.01	0.007	0	42.6	36.5	75.7	133	117	0	34	32
2015	7	28	11	3	24	0.823	-0.102	4.154	0.01	0.007	0	42.6	36.5	75.7	133	117	0	34	32
2015	7	28	11	13	24	0.794	-0.089	4.154	0.01	0.007	0	41.7	35.7	76.1	131	115	0	34	32
2015	7	28	11	23	24	0.81	-0.079	4.154	0.01	0.007	0	41.7	36.1	75.7	131	116	0	34	32
2015	7	28	11	33	24	0.781	-0.069	4.154	0.01	0.007	0	41.7	36.5	76.5	132	117	0	35	32
2015	7	28	11	43	24	0.761	-0.128	4.154	0.01	0.007	0	41.7	36.1	77.4	132	116	0	35	32
2015	7	28	11	53	24	0.787	-0.069	4.154	0.01	0.007	0	42.1	36.1	76.5	132	116	0	34	32
2015	7	28	12	3	24	0.804	-0.059	4.154	0.013	0.01	0	41.7	36.5	77.4	132	116	0	35	31
2015	7	28	12	13	24	0.771	-0.092	4.154	0.013	0.01	0	41.7	36.1	77	131	116	0	34	32
2015	7	28	12	23	24	0.807	-0.082	4.154	0.013	0.01	0	42.6	36.5	76.5	133	117	0	34	32
2015	7	28	12	33	24	0.778	-0.108	4.154	0.01	0.007	0	42.6	36.1	77.8	133	117	0	34	33
2015	7	28	12	43	24	0.784	-0.095	4.154	0.01	0.007	0	42.1	36.5	78.3	133	117	0	35	32
2015	7	28	12	53	24	0.82	-0.075	4.154	0.01	0.007	0	42.1	36.1	77.4	132	116	0	34	32
2015	7	28	13	3	24	0.761	-0.085	4.154	0.01	0.007	0	41.7	36.5	77	132	117	0	35	32
2015	7	28	13	13	24	0.771	-0.125	4.154	0.01	0.007	0	42.1	36.1	77.4	132	116	0	34	32
2015	7	28	13	23	24	0.761	-0.085	4.154	0.01	0.007	0	42.1	36.5	77.8	132	116	0	34	31
2015	7	28	13	33	24	0.764	-0.108	4.15	0.01	0.007	0	41.7	36.5	78.3	132	116	0	35	31
2015	7	28	13	43	24	0.794	-0.095	4.15	0.01	0.007	0	41.7	36.1	72.7	131	115	0	34	31
2015	7	28	13	53	24	0.768	-0.066	4.15	0.01	0.007	0	42.1	36.1	66.2	132	115	0	34	31
2015	7	28	14	3	24	0.833	-0.095	4.15	0.013	0.01	0	41.7	36.1	77.4	131	115	0	34	31
2015	7	28	14	13	24	0.807	-0.095	4.15	0.01	0.007	0	41.7	35.7	77.4	131	115	0	34	32
2015	7	28	14	23	24	0.794	-0.092	4.15	0.01	0.007	0	41.3	35.7	73.5	130	115	0	34	32
2015	7	28	14	33	24	0.748	-0.089	4.15	0.01	0.007	0	41.7	35.7	77	131	115	0	34	32
2015	7	28	14	43	24	0.787	-0.098	4.147	0.01	0.007	0	41.7	36.1	69.2	131	115	0	34	31
2015	7	28	14	53	24	0.778	-0.092	4.147	0.01	0.007	0	41.7	35.7	70.5	131	115	0	34	32
2015	7	28	15	3	24	0.768	-0.112	4.147	0.013	0.01	0	41.3	36.1	71.4	131	115	0	35	31
2015	7	28	15	13	24	0.764	-0.062	4.147	0.01	0.007	0	41.3	35.7	70.5	131	115	0	35	32
2015	7	28	15	23	24	0.738	-0.098	4.147	0.01	0.007	0	41.7	35.7	71.8	131	115	0	34	32
2015	7	28	15	33	24	0.751	-0.112	4.144	0.01	0.007	0	41.3	36.1	71.8	130	115	0	34	31
2015	7	28	15	43	24	0.771	-0.108	4.144	0.01	0.007	0	41.7	35.7	74.4	131	115	0	34	32
2015	7	28	15	53	24	0.797	-0.105	4.144	0.01	0.007	0	41.7	35.7	75.7	131	114	0	34	31
2015	7	28	16	3	24	0.745	-0.112	4.144	0.01	0.007	0	41.3	36.1	74.8	131	115	0	35	31
2015	7	28	16	13	24	0.787	-0.082	4.14	0.01	0.007	0	41.7	35.7	74.8	131	115	0	34	32
2015	7	28	16	23	24	0.774	-0.082	4.14	0.01	0.007	0	42.6	36.1	72.2	132	116	0	33	32
2015	7	28	16	33	24	0.801	-0.092	4.137	0.01	0.007	0	42.1	36.5	73.5	132	116	0	34	31
2015	7	28	16	43	24	0.768	-0.092	4.134	0.01	0.007	0	42.1	36.5	74.8	132	116	0	34	31
2015	7	28	16	53	24	0.787	-0.062	4.134	0.01	0.007	0	42.1	36.5	74.4	132	116	0	34	31
2015	7	28	17	3	24	0.781	-0.095	4.131	0.016	0.013	0	42.1	36.5	73.5	132	116	0	34	31
2015	7	28	17	13	24	0.794	-0.102	4.127	0.01	0.007	0	42.6	37	71.4	133	117	0	34	31
2015	7	28	17	23	24	0.778	-0.069	4.127	0.01	0.007	0	45.6	40	50.7	140	124	0	34	31
2015	7	28	17	33	24	0.81	-0.102	4.131	0.01	0.007	0	44.7	38.7	50.3	138	122	0	34	32
2015	7	28	17	43	24	0.787	-0.059	4.127	0.01	0.007	0	43.9	38.3	52	137	121	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	28	17	53	24	0.791	-0.082	4.131	0.01	0.007	0	44.7	38.7	55	138	121	0	34	31
2015	7	28	18	3	24	0.797	-0.072	4.127	0.016	0.013	0	46.9	40.4	47.3	143	126	0	34	32
2015	7	28	18	13	24	0.797	-0.112	4.124	0.01	0.007	0	42.1	36.5	67.5	132	117	0	34	32
2015	7	28	18	23	24	0.83	-0.089	4.124	0.01	0.007	0	43	37.4	50.3	134	118	0	34	31
2015	7	28	18	33	24	0.791	-0.128	4.124	0.01	0.007	0	43	37.4	55	134	118	0	34	31
2015	7	28	18	43	24	0.81	-0.079	4.124	0.01	0.007	0	45.2	39.6	47.3	139	123	0	34	31
2015	7	28	18	53	24	0.83	-0.049	4.121	0.01	0.007	0	46.9	41.3	43	143	128	0	34	32
2015	7	28	19	3	24	0.814	-0.062	4.121	0.016	0.013	0	46.9	41.7	43	143	129	0	34	32
2015	7	28	19	13	24	0.866	-0.085	4.121	0.016	0.013	0	47.3	41.7	46.4	144	128	0	34	31
2015	7	28	19	23	24	0.86	-0.052	4.121	0.01	0.007	0	47.3	41.7	45.6	144	128	0	34	31
2015	7	28	19	33	24	0.856	-0.062	4.124	0.01	0.007	0	45.2	39.1	46.9	139	122	0	34	31
2015	7	28	19	43	24	0.787	-0.066	4.124	0.016	0.013	0	45.6	40.9	46	140	126	0	34	31
2015	7	28	19	53	24	0.83	-0.079	4.124	0.013	0.01	0	46.9	41.3	46.4	143	128	0	34	32
2015	7	28	20	3	24	0.873	-0.072	4.121	0.01	0.007	0	46	41.3	46	142	127	0	35	31
2015	7	28	20	13	24	0.827	-0.059	4.117	0.01	0.007	0	45.2	40.4	46.4	140	125	0	35	31
2015	7	28	20	23	24	0.81	-0.052	4.117	0.01	0.007	0	49	43	44.3	148	132	0	34	32
2015	7	28	20	33	24	0.794	-0.075	4.121	0.013	0.01	0	43.9	38.3	60.6	136	120	0	34	31
2015	7	28	20	43	24	0.781	-0.105	4.121	0.01	0.007	0	42.6	37.4	76.1	133	118	0	34	31
2015	7	28	20	53	24	0.843	-0.079	4.121	0.01	0.007	0	42.1	37	76.1	133	118	0	35	32
2015	7	28	21	3	24	0.807	-0.089	4.121	0.01	0.007	0	42.6	37	75.3	133	118	0	34	32
2015	7	28	21	13	24	0.801	-0.095	4.121	0.01	0.007	0	42.6	37	76.1	133	118	0	34	32
2015	7	28	21	23	24	0.778	-0.059	4.121	0.01	0.007	0	42.6	37	75.7	133	118	0	34	32
2015	7	28	21	33	24	0.758	-0.066	4.117	0.013	0.01	0	42.1	37	76.1	132	117	0	34	31
2015	7	28	21	43	24	0.784	-0.098	4.117	0.013	0.01	0	41.7	36.5	76.1	131	116	0	34	31
2015	7	28	21	53	24	0.778	-0.102	4.117	0.013	0.01	0	41.7	36.5	77	131	116	0	34	31
2015	7	28	22	3	24	0.784	-0.098	4.117	0.013	0.01	0	42.1	36.1	76.1	132	116	0	34	32
2015	7	28	22	13	24	0.801	-0.082	4.117	0.013	0.01	0	42.1	36.1	77	132	116	0	34	32
2015	7	28	22	23	24	0.814	-0.089	4.117	0.013	0.01	0	41.7	36.1	76.5	131	116	0	34	32
2015	7	28	22	33	24	0.768	-0.098	4.117	0.013	0.01	0	41.7	36.5	76.1	131	116	0	34	31
2015	7	28	22	43	24	0.797	-0.098	4.117	0.013	0.01	0	41.7	36.5	76.5	131	116	0	34	31
2015	7	28	22	53	24	0.804	-0.118	4.117	0.01	0.007	0	41.7	36.5	76.5	132	116	0	35	31
2015	7	28	23	3	24	0.764	-0.118	4.117	0.013	0.01	0	41.7	35.7	77	131	115	0	34	32
2015	7	28	23	13	24	0.778	-0.069	4.117	0.01	0.007	0	41.7	36.1	76.5	131	116	0	34	32
2015	7	28	23	23	24	0.774	-0.098	4.114	0.01	0.007	0	42.1	36.5	76.5	132	116	0	34	31
2015	7	28	23	33	24	0.787	-0.079	4.117	0.01	0.007	0	41.3	36.5	76.1	131	116	0	35	31
2015	7	28	23	43	24	0.774	-0.072	4.117	0.01	0.007	0	42.1	36.5	77	132	117	0	34	32
2015	7	28	23	53	24	0.794	-0.128	4.114	0.01	0.007	0	41.7	36.1	74.8	131	116	0	34	32
2015	7	29	0	3	24	0.804	-0.069	4.114	0.016	0.013	0	41.3	36.1	76.5	131	116	0	35	32
2015	7	29	0	13	24	0.768	-0.089	4.114	0.01	0.007	0	41.7	36.5	76.1	131	116	0	34	31
2015	7	29	0	23	24	0.827	-0.095	4.114	0.01	0.007	0	41.3	36.5	76.5	131	116	0	35	31
2015	7	29	0	33	24	0.814	-0.112	4.114	0.016	0.016	0	40.9	35.7	76.5	130	115	0	35	32
2015	7	29	0	43	24	0.814	-0.085	4.114	0.01	0.007	0	41.7	36.1	77	131	116	0	34	32
2015	7	29	0	53	24	0.768	-0.066	4.114	0.013	0.01	0	42.1	36.5	77	132	117	0	34	32
2015	7	29	1	3	24	0.755	-0.069	4.114	0.01	0.007	0	42.1	36.1	76.1	132	116	0	34	32
2015	7	29	1	13	24	0.768	-0.082	4.114	0.013	0.01	0	41.7	36.5	76.5	131	116	0	34	31
2015	7	29	1	23	24	0.797	-0.095	4.114	0.013	0.01	0	41.7	36.1	76.1	131	116	0	34	32
2015	7	29	1	33	24	0.814	-0.079	4.114	0.01	0.007	0	42.6	37	76.5	133	117	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	29	1	43	24	0.761	-0.108	4.111	0.01	0.007	0	42.1	36.5	76.1	132	117	0	34	32
2015	7	29	1	53	24	0.771	-0.102	4.114	0.01	0.007	0	42.6	37	76.1	133	118	0	34	32
2015	7	29	2	3	24	0.761	-0.095	4.111	0.013	0.01	0	42.1	37.4	76.5	132	118	0	34	31
2015	7	29	2	13	24	0.768	-0.105	4.111	0.01	0.007	0	42.1	36.1	76.5	132	117	0	34	33
2015	7	29	2	23	24	0.81	-0.105	4.111	0.01	0.007	0	42.1	36.5	76.1	132	117	0	34	32
2015	7	29	2	33	24	0.761	-0.079	4.111	0.013	0.01	0	41.7	36.5	76.1	132	117	0	35	32
2015	7	29	2	43	24	0.807	-0.115	4.111	0.01	0.007	0	42.1	36.5	77	132	117	0	34	32
2015	7	29	2	53	24	0.761	-0.066	4.111	0.01	0.007	0	42.1	36.5	76.5	132	117	0	34	32
2015	7	29	3	3	24	0.758	-0.105	4.111	0.01	0.007	0	41.7	36.1	76.1	131	116	0	34	32
2015	7	29	3	13	24	0.758	-0.072	4.111	0.016	0.013	0	41.7	36.5	76.5	132	117	0	35	32
2015	7	29	3	23	24	0.771	-0.082	4.111	0.01	0.007	0	42.1	37	75.7	132	117	0	34	31
2015	7	29	3	33	24	0.82	-0.075	4.108	0.016	0.013	0	42.1	37	76.5	133	118	0	35	32
2015	7	29	3	43	24	0.764	-0.095	4.108	0.01	0.007	0	41.7	36.5	76.5	132	117	0	35	32
2015	7	29	3	53	24	0.801	-0.115	4.108	0.01	0.007	0	42.1	37	76.5	132	117	0	34	31
2015	7	29	4	3	24	0.797	-0.069	4.108	0.01	0.007	0	42.1	36.5	76.1	132	117	0	34	32
2015	7	29	4	13	24	0.748	-0.108	4.108	0.01	0.007	0	41.7	36.5	77	132	116	0	35	31
2015	7	29	4	23	24	0.791	-0.079	4.108	0.01	0.007	0	42.1	36.5	75.7	132	117	0	34	32
2015	7	29	4	33	24	0.741	-0.079	4.108	0.013	0.01	0	42.1	36.5	75.3	132	117	0	34	32
2015	7	29	4	43	24	0.781	-0.095	4.108	0.01	0.007	0	42.1	36.5	76.5	132	117	0	34	32
2015	7	29	4	53	24	0.801	-0.121	4.108	0.01	0.007	0	42.1	36.5	76.5	132	117	0	34	32
2015	7	29	5	3	24	0.764	-0.095	4.108	0.013	0.01	0	42.1	36.1	76.1	132	117	0	34	33
2015	7	29	5	13	24	0.787	-0.105	4.108	0.01	0.007	0	42.1	37	76.5	133	117	0	35	31
2015	7	29	5	23	24	0.778	-0.089	4.104	0.013	0.01	0	42.6	37	77	134	118	0	35	32
2015	7	29	5	33	24	0.814	-0.092	4.104	0.013	0.01	0	42.6	37.4	76.5	134	119	0	35	32
2015	7	29	5	43	24	0.761	-0.082	4.104	0.01	0.007	0	43	37.4	76.1	134	119	0	34	32
2015	7	29	5	53	24	0.784	-0.098	4.104	0.01	0.007	0	43	37.8	76.1	134	119	0	34	31
2015	7	29	6	3	24	0.787	-0.072	4.104	0.01	0.007	0	43	37.4	76.5	134	119	0	34	32
2015	7	29	6	13	24	0.741	-0.082	4.104	0.01	0.007	0	42.6	37	76.5	133	118	0	34	32
2015	7	29	6	23	24	0.778	-0.098	4.104	0.013	0.01	0	42.6	37	76.5	133	118	0	34	32
2015	7	29	6	33	24	0.814	-0.102	4.104	0.01	0.007	0	41.7	36.5	76.5	132	117	0	35	32
2015	7	29	6	43	24	0.804	-0.092	4.104	0.01	0.007	0	42.1	36.5	77	132	117	0	34	32
2015	7	29	6	53	24	0.791	-0.085	4.104	0.01	0.007	0	41.7	36.5	76.1	132	117	0	35	32
2015	7	29	7	3	24	0.797	-0.059	4.104	0.01	0.007	0	41.7	36.1	77	131	116	0	34	32
2015	7	29	7	13	24	0.748	-0.108	4.101	0.01	0.007	0	41.7	36.1	76.1	131	116	0	34	32
2015	7	29	7	23	24	0.768	-0.118	4.101	0.01	0.007	0	41.3	36.5	77	131	116	0	35	31
2015	7	29	7	33	24	0.768	-0.105	4.101	0.01	0.007	0	41.7	36.1	76.1	132	116	0	35	32
2015	7	29	7	43	24	0.82	-0.089	4.101	0.013	0.01	0	41.3	36.1	75.7	131	116	0	35	32
2015	7	29	7	53	24	0.761	-0.062	4.101	0.013	0.01	0	42.1	37	77	132	117	0	34	31
2015	7	29	8	3	24	0.751	-0.079	4.101	0.01	0.007	0	42.1	36.5	77.4	132	117	0	34	32
2015	7	29	8	13	24	0.751	-0.066	4.101	0.016	0.013	0	43	37.4	77.4	134	119	0	34	32
2015	7	29	8	23	24	0.774	-0.079	4.101	0.01	0.007	0	42.1	37.4	76.5	133	119	0	35	32
2015	7	29	8	33	24	0.784	-0.128	4.101	0.01	0.007	0	42.6	37	77	133	118	0	34	32
2015	7	29	8	43	24	0.837	-0.066	4.098	0.01	0.007	0	42.6	37	76.5	133	118	0	34	32
2015	7	29	8	53	24	0.791	-0.059	4.098	0.01	0.007	0	42.6	37.4	77.4	133	118	0	34	31
2015	7	29	9	3	24	0.781	-0.095	4.098	0.01	0.007	0	41.7	37	76.1	132	118	0	35	32
2015	7	29	9	13	24	0.751	-0.082	4.098	0.013	0.01	0	42.6	37	75.3	133	118	0	34	32
2015	7	29	9	23	24	0.784	-0.095	4.098	0.013	0.01	0	42.1	37.4	76.1	133	119	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	29	9	33	24	0.778	-0.089	4.098	0.01	0.007	0	43	38.3	75.3	134	120	0	34	31
2015	7	29	9	43	24	0.764	-0.095	4.094	0.01	0.007	0	42.6	37	75.3	133	118	0	34	32
2015	7	29	9	53	24	0.791	-0.079	4.094	0.01	0.007	0	41.7	37.4	74	132	118	0	35	31
2015	7	29	10	3	24	0.755	-0.089	4.094	0.01	0.007	0	42.1	36.5	74.8	132	117	0	34	32
2015	7	29	10	13	24	0.794	-0.095	4.091	0.01	0.007	0	42.1	37	74	133	118	0	35	32
2015	7	29	10	23	24	0.758	-0.082	4.091	0.01	0.007	0	42.1	37	72.2	133	118	0	35	32
2015	7	29	10	33	24	0.761	-0.095	4.085	0.013	0.01	0	42.6	37	73.1	133	118	0	34	32
2015	7	29	10	43	24	0.705	-0.115	4.081	0.016	0.016	0	41.7	36.5	72.2	132	117	0	35	32
2015	7	29	10	53	24	0.758	-0.095	4.078	0.01	0.007	0	41.7	37	73.1	132	118	0	35	32
2015	7	29	11	3	24	0.771	-0.118	4.078	0.013	0.01	0	42.1	37	74	133	118	0	35	32
2015	7	29	11	13	24	0.764	-0.108	4.078	0.013	0.01	0	41.7	36.5	74.4	132	117	0	35	32
2015	7	29	11	23	24	0.794	-0.098	4.078	0.013	0.01	0	41.7	35.7	74	131	116	0	34	33
2015	7	29	11	33	24	0.745	-0.089	4.078	0.01	0.007	0	41.3	35.7	74.8	130	116	0	34	33
2015	7	29	11	43	24	0.761	-0.098	4.075	0.01	0.007	0	41.7	36.5	75.3	131	117	0	34	32
2015	7	29	11	53	24	0.794	-0.098	4.075	0.01	0.007	0	41.7	37	75.3	132	117	0	35	31
2015	7	29	12	3	24	0.755	-0.092	4.075	0.01	0.007	0	42.6	37.4	76.5	133	118	0	34	31
2015	7	29	12	13	24	0.745	-0.095	4.075	0.01	0.007	0	42.1	37	75.3	132	118	0	34	32
2015	7	29	12	23	24	0.758	-0.098	4.072	0.01	0.007	0	41.7	36.1	76.1	131	116	0	34	32
2015	7	29	12	33	24	0.784	-0.105	4.072	0.013	0.01	0	41.3	36.5	76.5	131	117	0	35	32
2015	7	29	12	43	24	0.778	-0.098	4.072	0.01	0.007	0	41.3	36.1	77.4	130	116	0	34	32
2015	7	29	12	53	24	0.771	-0.085	4.072	0.01	0.007	0	41.3	36.5	74.8	131	116	0	35	31
2015	7	29	13	3	24	0.751	-0.062	4.072	0.01	0.007	0	41.7	36.1	63.6	131	116	0	34	32
2015	7	29	13	13	24	0.745	-0.089	4.072	0.01	0.007	0	41.7	36.5	71.4	131	116	0	34	31
2015	7	29	13	23	24	0.728	-0.082	4.072	0.013	0.01	0	41.3	36.5	60.2	131	117	0	35	32
2015	7	29	13	33	24	0.781	-0.062	4.068	0.016	0.013	0	42.1	36.5	62.8	132	117	0	34	32
2015	7	29	13	43	24	0.715	-0.089	4.068	0.013	0.01	0	41.7	36.5	56.8	131	117	0	34	32
2015	7	29	13	53	24	0.771	-0.102	4.065	0.013	0.01	0	41.7	36.5	65.8	131	117	0	34	32
2015	7	29	14	3	24	0.719	-0.112	4.068	0.01	0.007	0	41.3	36.1	74.4	131	116	0	35	32
2015	7	29	14	13	24	0.686	-0.089	4.062	0.01	0.007	0	41.7	36.5	55.5	131	117	0	34	32
2015	7	29	14	23	24	0.748	-0.095	4.062	0.01	0.007	0	42.1	37	66.2	132	118	0	34	32
2015	7	29	14	33	24	0.738	-0.102	4.062	0.01	0.007	0	42.1	37	66.2	132	118	0	34	32
2015	7	29	14	43	24	0.787	-0.112	4.058	0.01	0.007	0	42.1	36.5	65.8	132	117	0	34	32
2015	7	29	14	53	24	0.751	-0.082	4.052	0.01	0.007	0	42.1	37	65.8	132	117	0	34	31
2015	7	29	15	3	24	0.719	-0.082	4.052	0.01	0.007	0	42.1	36.5	55.9	132	117	0	34	32
2015	7	29	15	13	24	0.728	-0.075	4.049	0.01	0.007	0	42.6	37	71	133	118	0	34	32
2015	7	29	15	23	24	0.771	-0.108	4.045	0.01	0.007	0	42.1	36.1	66.2	132	117	0	34	33
2015	7	29	15	33	24	0.751	-0.082	4.045	0.01	0.007	0	42.1	36.5	65.4	132	117	0	34	32
2015	7	29	15	43	24	0.725	-0.089	4.042	0.01	0.007	0	41.7	36.1	71.4	131	116	0	34	32
2015	7	29	15	53	24	0.741	-0.079	4.045	0.01	0.007	0	41.7	36.5	73.1	131	116	0	34	31
2015	7	29	16	3	24	0.748	-0.089	4.042	0.016	0.013	0	41.7	36.5	56.8	131	116	0	34	31
2015	7	29	16	13	24	0.784	-0.085	4.042	0.01	0.007	0	42.1	36.5	72.2	132	117	0	34	32
2015	7	29	16	23	24	0.748	-0.102	4.039	0.013	0.01	0	42.1	37	64.9	132	117	0	34	31
2015	7	29	16	33	24	0.748	-0.105	4.039	0.01	0.007	0	42.1	37.4	74	132	118	0	34	31
2015	7	29	16	43	24	0.761	-0.092	4.039	0.01	0.007	0	42.6	37	65.8	133	118	0	34	32
2015	7	29	16	53	24	0.738	-0.102	4.039	0.013	0.01	0	42.6	37	71.8	133	118	0	34	32
2015	7	29	17	3	24	0.768	-0.092	4.039	0.01	0.007	0	42.1	37	69.2	132	117	0	34	31
2015	7	29	17	13	24	0.745	-0.075	4.039	0.01	0.007	0	42.1	36.5	67.1	132	117	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	29	17	23	24	0.768	-0.085	4.035	0.013	0.01	0	41.7	37	71	131	117	0	34	31
2015	7	29	17	33	24	0.735	-0.082	4.035	0.016	0.013	0	41.7	36.5	69.2	131	116	0	34	31
2015	7	29	17	43	24	0.715	-0.121	4.035	0.01	0.007	0	41.3	35.7	76.1	130	115	0	34	32
2015	7	29	17	53	24	0.758	-0.095	4.035	0.013	0.01	0	41.7	36.1	77.4	131	116	0	34	32
2015	7	29	18	3	24	0.781	-0.105	4.035	0.013	0.01	0	41.3	35.3	77	130	114	0	34	32
2015	7	29	18	13	24	0.705	-0.082	4.035	0.01	0.007	0	41.3	36.1	62.4	131	116	0	35	32
2015	7	29	18	23	24	0.732	-0.095	4.032	0.013	0.01	0	41.7	35.7	55	131	115	0	34	32
2015	7	29	18	33	24	0.735	-0.052	4.029	0.013	0.01	0	43.9	38.3	53.8	136	121	0	34	32
2015	7	29	18	43	24	0.728	-0.082	4.029	0.013	0.01	0	45.6	39.6	56.3	140	124	0	34	32
2015	7	29	18	53	24	0.751	-0.085	4.029	0.01	0.007	0	44.3	38.7	55.5	137	122	0	34	32
2015	7	29	19	3	24	0.686	-0.069	4.026	0.01	0.007	0	46	40.4	48.2	141	125	0	34	31
2015	7	29	19	13	24	0.735	-0.092	4.022	0.01	0.007	0	46.9	40.9	44.7	143	127	0	34	32
2015	7	29	19	23	24	0.722	-0.059	4.026	0.013	0.01	0	46.9	40.9	45.6	143	126	0	34	31
2015	7	29	19	33	24	0.807	-0.066	4.022	0.01	0.007	0	50.3	44.7	39.1	151	135	0	34	31
2015	7	29	19	43	24	0.755	-0.016	4.019	0.01	0.007	0	52	46.9	39.1	155	140	0	34	31
2015	7	29	19	53	24	0.794	-0.033	4.019	0.013	0.01	0	50.7	44.7	38.7	153	136	0	35	32
2015	7	29	20	3	24	0.817	-0.052	4.022	0.01	0.007	0	47.7	41.7	43.9	145	129	0	34	32
2015	7	29	20	13	24	0.748	-0.023	4.016	0.01	0.007	0	51.6	46.9	36.5	155	140	0	35	31
2015	7	29	20	23	24	0.722	-0.075	4.022	0.01	0.007	0	48.6	43.4	43	147	132	0	34	31
2015	7	29	20	33	24	0.735	-0.128	4.029	0.01	0.007	0	41.7	37	72.7	132	117	0	35	31
2015	7	29	20	43	24	0.801	-0.085	4.029	0.01	0.007	0	41.3	36.1	74.8	131	116	0	35	32
2015	7	29	20	53	24	0.728	-0.102	4.026	0.013	0.01	0	41.3	36.5	70.1	130	116	0	34	31
2015	7	29	21	3	24	0.715	-0.098	4.026	0.01	0.007	0	41.3	35.7	67.5	130	115	0	34	32
2015	7	29	21	13	24	0.702	-0.085	4.022	0.01	0.007	0	41.3	35.7	64.5	130	116	0	34	33
2015	7	29	21	23	24	0.755	-0.075	4.022	0.01	0.007	0	41.7	37	55.9	132	117	0	35	31
2015	7	29	21	33	24	0.725	-0.079	4.022	0.013	0.01	0	41.3	37	57.2	131	117	0	35	31
2015	7	29	21	43	24	0.738	-0.098	4.022	0.01	0.007	0	42.6	37	54.6	133	117	0	34	31
2015	7	29	21	53	24	0.728	-0.098	4.022	0.013	0.01	0	42.1	37	60.6	133	118	0	35	32
2015	7	29	22	3	24	0.778	-0.075	4.019	0.01	0.007	0	42.6	37	56.8	133	118	0	34	32
2015	7	29	22	13	24	0.735	-0.105	4.019	0.01	0.007	0	42.1	36.5	53.8	132	117	0	34	32
2015	7	29	22	23	24	0.745	-0.108	4.019	0.01	0.007	0	42.1	36.5	56.8	132	117	0	34	32
2015	7	29	22	33	24	0.764	-0.092	4.019	0.01	0.007	0	42.1	36.5	54.6	132	117	0	34	32
2015	7	29	22	43	24	0.781	-0.089	4.019	0.01	0.007	0	42.1	37.4	63.6	133	118	0	35	31
2015	7	29	22	53	24	0.761	-0.098	4.019	0.01	0.007	0	42.1	36.5	67.1	132	117	0	34	32
2015	7	29	23	3	24	0.748	-0.079	4.019	0.01	0.007	0	41.3	36.1	66.7	130	116	0	34	32
2015	7	29	23	13	24	0.725	-0.079	4.016	0.013	0.01	0	42.1	36.5	60.6	132	117	0	34	32
2015	7	29	23	23	24	0.764	-0.082	4.016	0.013	0.01	0	40.9	36.1	62.4	130	115	0	35	31
2015	7	29	23	33	24	0.728	-0.115	4.019	0.013	0.01	0	42.1	36.5	64.1	132	117	0	34	32
2015	7	29	23	43	24	0.751	-0.066	4.016	0.01	0.007	0	41.3	36.5	62.4	131	117	0	35	32
2015	7	29	23	53	24	0.715	-0.112	4.016	0.013	0.01	0	41.7	36.1	64.9	131	116	0	34	32
2015	7	30	0	3	24	0.738	-0.148	4.016	0.013	0.01	0	41.7	36.1	64.9	131	116	0	34	32
2015	7	30	0	13	24	0.738	-0.112	4.016	0.013	0.01	0	41.7	36.1	70.1	131	116	0	34	32
2015	7	30	0	23	24	0.735	-0.082	4.016	0.013	0.01	0	41.3	35.7	64.5	130	115	0	34	32
2015	7	30	0	33	24	0.751	-0.098	4.016	0.013	0.01	0	40.9	36.5	72.2	130	116	0	35	31
2015	7	30	0	43	24	0.764	-0.131	4.016	0.016	0.013	0	41.7	36.1	72.7	131	116	0	34	32
2015	7	30	0	53	24	0.748	-0.066	4.012	0.016	0.013	0	41.7	36.1	65.8	130	116	0	33	32
2015	7	30	1	3	24	0.781	-0.128	4.012	0.013	0.01	0	41.3	35.7	72.7	130	115	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	30	1	13	24	0.735	-0.092	4.012	0.01	0.007	0	41.7	36.1	72.7	131	116	0	34	32
2015	7	30	1	23	24	0.722	-0.102	4.012	0.01	0.007	0	41.3	36.1	72.7	130	116	0	34	32
2015	7	30	1	33	24	0.784	-0.079	4.012	0.01	0.007	0	41.3	36.1	71.8	130	116	0	34	32
2015	7	30	1	43	24	0.738	-0.108	4.012	0.01	0.007	0	42.1	37	72.2	132	117	0	34	31
2015	7	30	1	53	24	0.741	-0.095	4.012	0.01	0.007	0	41.7	36.5	72.7	131	117	0	34	32
2015	7	30	2	3	24	0.764	-0.108	4.012	0.01	0.007	0	42.1	36.5	72.2	132	117	0	34	32
2015	7	30	2	13	24	0.784	-0.112	4.012	0.01	0.007	0	41.7	36.5	72.2	131	117	0	34	32
2015	7	30	2	23	24	0.741	-0.079	4.012	0.01	0.007	0	41.7	36.5	73.1	131	117	0	34	32
2015	7	30	2	33	24	0.764	-0.072	4.016	0.013	0.01	0	41.3	36.5	73.1	130	116	0	34	31
2015	7	30	2	43	24	0.771	-0.092	4.012	0.01	0.007	0	41.3	36.5	72.7	130	116	0	34	31
2015	7	30	2	53	24	0.781	-0.098	4.012	0.013	0.01	0	41.3	36.1	73.1	131	116	0	35	32
2015	7	30	3	3	24	0.764	-0.062	4.012	0.01	0.007	0	41.3	36.5	72.2	130	116	0	34	31
2015	7	30	3	13	24	0.751	-0.112	4.012	0.013	0.01	0	41.3	35.7	73.1	130	115	0	34	32
2015	7	30	3	23	24	0.771	-0.082	4.012	0.01	0.007	0	41.3	36.1	72.2	130	116	0	34	32
2015	7	30	3	33	24	0.778	-0.085	4.012	0.01	0.007	0	40.9	35.7	71.8	129	115	0	34	32
2015	7	30	3	43	24	0.751	-0.066	4.012	0.01	0.007	0	40.9	36.1	73.1	130	115	0	35	31
2015	7	30	3	53	24	0.735	-0.082	4.012	0.01	0.007	0	41.3	36.1	73.5	130	116	0	34	32
2015	7	30	4	3	24	0.758	-0.089	4.012	0.01	0.007	0	41.3	35.7	72.2	130	115	0	34	32
2015	7	30	4	13	24	0.804	-0.095	4.012	0.016	0.013	0	40.9	35.3	72.7	129	114	0	34	32
2015	7	30	4	23	24	0.741	-0.095	4.012	0.01	0.007	0	41.3	36.1	71.8	130	115	0	34	31
2015	7	30	4	33	24	0.781	-0.066	4.012	0.01	0.007	0	41.7	36.5	73.1	131	116	0	34	31
2015	7	30	4	43	24	0.797	-0.079	4.012	0.01	0.007	0	41.7	36.1	71.8	131	115	0	34	31
2015	7	30	4	53	24	0.827	-0.115	4.012	0.01	0.007	0	41.7	36.5	72.7	131	116	0	34	31
2015	7	30	5	3	24	0.725	-0.082	4.016	0.01	0.007	0	42.1	36.5	72.7	132	117	0	34	32
2015	7	30	5	13	24	0.778	-0.128	4.012	0.013	0.01	0	42.1	36.5	69.7	132	116	0	34	31
2015	7	30	5	23	24	0.745	-0.095	4.016	0.01	0.007	0	42.1	37	72.7	132	117	0	34	31
2015	7	30	5	33	24	0.768	-0.089	4.016	0.01	0.007	0	42.6	37.4	72.2	133	118	0	34	31
2015	7	30	5	43	24	0.797	-0.046	4.012	0.01	0.007	0	42.6	37.8	72.2	134	119	0	35	31
2015	7	30	5	53	24	0.755	-0.075	4.016	0.01	0.007	0	43.4	37.4	72.2	135	120	0	34	33
2015	7	30	6	3	24	0.745	-0.082	4.016	0.01	0.007	0	43	37.8	72.7	135	120	0	35	32
2015	7	30	6	13	24	0.781	-0.075	4.016	0.01	0.007	0	43	37.4	73.1	134	119	0	34	32
2015	7	30	6	23	24	0.771	-0.082	4.016	0.01	0.007	0	42.6	37.4	72.7	134	119	0	35	32
2015	7	30	6	33	24	0.745	-0.095	4.016	0.01	0.007	0	43	37.4	72.7	134	119	0	34	32
2015	7	30	6	43	24	0.755	-0.082	4.016	0.01	0.007	0	42.1	37	73.5	133	118	0	35	32
2015	7	30	6	53	24	0.794	-0.121	4.016	0.013	0.01	0	42.6	37	72.2	133	118	0	34	32
2015	7	30	7	3	24	0.771	-0.095	4.016	0.01	0.007	0	42.1	37	73.5	133	118	0	35	32
2015	7	30	7	13	24	0.794	-0.079	4.016	0.01	0.007	0	42.6	37	73.5	133	118	0	34	32
2015	7	30	7	23	24	0.778	-0.115	4.019	0.01	0.007	0	42.6	37	73.5	133	118	0	34	32
2015	7	30	7	33	24	0.725	-0.112	4.016	0.013	0.01	0	41.7	36.5	72.7	132	117	0	35	32
2015	7	30	8	1	37	0.774	-0.121	4.016	0.01	0.007	0	42.1	37.4	73.5	132	118	0	34	31
2015	7	30	8	23	16	0.774	-0.105	4.019	0.013	0.01	0	42.6	37	73.5	133	118	0	34	32
2015	7	30	8	33	16	0.794	-0.082	4.019	0.013	0.01	0	41.7	36.5	73.5	132	117	0	35	32
2015	7	30	8	43	16	0.781	-0.059	4.019	0.01	0.007	0	42.1	36.5	73.1	132	117	0	34	32
2015	7	30	8	53	16	0.738	-0.102	4.019	0.013	0.01	0	42.1	37	74	132	117	0	34	31
2015	7	30	9	3	16	0.738	-0.102	4.019	0.01	0.007	0	42.1	37	73.1	132	118	0	34	32
2015	7	30	9	13	16	0.761	-0.075	4.016	0.01	0.007	0	41.7	36.5	73.1	132	117	0	35	32
2015	7	30	9	23	16	0.725	-0.095	4.016	0.01	0.007	0	42.1	37	72.7	132	117	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	30	9	33	16	0.771	-0.135	4.016	0.013	0.01	0	42.1	37.4	73.5	133	118	0	35	31
2015	7	30	9	43	16	0.807	-0.115	4.016	0.01	0.007	0	42.1	36.5	73.5	132	117	0	34	32
2015	7	30	9	53	16	0.791	-0.112	4.016	0.013	0.01	0	41.7	36.5	73.1	131	117	0	34	32
2015	7	30	10	3	16	0.761	-0.075	4.012	0.01	0.007	0	42.1	37	73.5	132	117	0	34	31
2015	7	30	10	13	16	0.761	-0.089	4.016	0.01	0.007	0	41.7	36.5	73.1	132	117	0	35	32
2015	7	30	10	23	16	0.751	-0.082	4.012	0.013	0.01	0	41.7	37	72.7	132	118	0	35	32
2015	7	30	10	33	16	0.735	-0.095	4.012	0.013	0.01	0	42.1	37.8	73.1	133	119	0	35	31
2015	7	30	10	43	16	0.755	-0.092	4.009	0.013	0.01	0	43	37.4	73.1	134	119	0	34	32
2015	7	30	10	53	16	0.741	-0.095	4.009	0.013	0.01	0	42.6	37.4	73.5	133	119	0	34	32
2015	7	30	11	3	16	0.755	-0.112	4.009	0.013	0.01	0	42.6	37	73.5	133	118	0	34	32
2015	7	30	11	13	16	0.741	-0.112	4.006	0.01	0.007	0	42.6	37.4	74	133	119	0	34	32
2015	7	30	11	23	16	0.781	-0.066	4.006	0.01	0.007	0	42.6	37.4	73.5	134	119	0	35	32
2015	7	30	11	33	16	0.781	-0.072	4.006	0.013	0.01	0	43	38.3	74	134	120	0	34	31
2015	7	30	11	43	16	0.764	-0.082	4.006	0.01	0.007	0	42.6	37.4	73.5	133	119	0	34	32
2015	7	30	11	53	16	0.715	-0.115	4.006	0.016	0.013	0	42.1	37.4	74	133	118	0	35	31
2015	7	30	12	3	16	0.735	-0.095	4.006	0.01	0.007	0	42.6	37.4	73.5	133	118	0	34	31
2015	7	30	12	13	16	0.725	-0.115	4.006	0.01	0.007	0	42.6	37	73.1	133	118	0	34	32
2015	7	30	12	23	16	0.755	-0.092	4.006	0.01	0.007	0	42.6	37.4	69.7	133	118	0	34	31
2015	7	30	12	33	16	0.781	-0.112	4.006	0.01	0.007	0	42.1	36.5	74	132	117	0	34	32
2015	7	30	12	43	16	0.758	-0.098	4.006	0.016	0.013	0	42.6	37.4	74.8	133	119	0	34	32
2015	7	30	12	53	16	0.715	-0.072	4.006	0.01	0.007	0	42.6	37	73.5	133	118	0	34	32
2015	7	30	13	3	16	0.719	-0.098	4.006	0.013	0.01	0	42.1	37	74	133	118	0	35	32
2015	7	30	13	13	16	0.751	-0.112	4.006	0.01	0.007	0	42.1	37.4	74	133	118	0	35	31
2015	7	30	13	23	16	0.735	-0.085	4.006	0.013	0.01	0	42.1	37.4	76.1	132	118	0	34	31
2015	7	30	13	33	16	0.758	-0.089	4.006	0.01	0.007	0	42.1	37.4	74.8	133	118	0	35	31
2015	7	30	13	43	16	0.764	-0.128	4.006	0.01	0.007	0	42.1	37	76.1	133	118	0	35	32
2015	7	30	13	53	16	0.751	-0.066	4.006	0.01	0.007	0	43	37.8	76.1	135	120	0	35	32
2015	7	30	14	3	16	0.741	-0.062	4.006	0.01	0.007	0	43	37.4	76.5	134	119	0	34	32
2015	7	30	14	13	16	0.745	-0.092	4.003	0.013	0.01	0	42.6	37.4	75.7	133	118	0	34	31
2015	7	30	14	23	16	0.748	-0.082	4.006	0.01	0.007	0	42.6	37.4	76.5	133	118	0	34	31
2015	7	30	14	33	16	0.755	-0.082	4.006	0.01	0.007	0	42.6	37	74.8	133	118	0	34	32
2015	7	30	14	43	16	0.784	-0.079	4.003	0.01	0.007	0	42.6	37	68.8	133	118	0	34	32
2015	7	30	14	53	16	0.741	-0.089	4.003	0.01	0.007	0	42.1	37.4	76.5	132	118	0	34	31
2015	7	30	15	3	16	0.768	-0.082	4.003	0.01	0.007	0	41.7	37	77.4	132	118	0	35	32
2015	7	30	15	13	16	0.705	-0.115	4.003	0.013	0.01	0	42.1	36.5	76.1	132	117	0	34	32
2015	7	30	15	23	16	0.745	-0.098	4.003	0.013	0.01	0	41.7	37.4	75.3	132	118	0	35	31
2015	7	30	15	33	16	0.705	-0.105	4.003	0.013	0.01	0	42.6	37	65.8	133	118	0	34	32
2015	7	30	15	43	16	0.702	-0.115	4.003	0.01	0.007	0	42.6	37.4	72.2	133	118	0	34	31
2015	7	30	15	53	16	0.738	-0.062	4.003	0.01	0.007	0	41.7	37.4	73.5	132	118	0	35	31
2015	7	30	16	3	16	0.722	-0.085	3.999	0.01	0.007	0	42.6	37	61.5	133	118	0	34	32
2015	7	30	16	13	16	0.732	-0.089	4.003	0.016	0.016	0	42.6	37.4	61.1	133	118	0	34	31
2015	7	30	16	23	16	0.755	-0.089	4.003	0.01	0.007	0	42.6	37.4	65.8	133	118	0	34	31
2015	7	30	16	33	16	0.702	-0.082	3.999	0.013	0.01	0	42.1	37	67.5	132	118	0	34	32
2015	7	30	16	43	16	0.732	-0.089	4.003	0.013	0.01	0	42.1	36.5	76.1	132	117	0	34	32
2015	7	30	16	53	16	0.761	-0.059	4.003	0.016	0.013	0	42.1	36.5	77.8	132	117	0	34	32
2015	7	30	17	3	16	0.725	-0.095	3.999	0.01	0.007	0	41.7	36.5	77	132	117	0	35	32
2015	7	30	17	13	16	0.722	-0.082	3.999	0.01	0.007	0	42.6	37.8	58	134	120	0	35	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	30	17	23	16	0.738	-0.105	3.999	0.013	0.01	0	42.6	37.8	62.4	133	119	0	34	31
2015	7	30	17	33	16	0.741	-0.115	3.999	0.01	0.007	0	42.6	37.4	67.9	132	118	0	33	31
2015	7	30	17	43	16	0.735	-0.066	3.999	0.016	0.013	0	42.1	37.4	77	133	118	0	35	31
2015	7	30	17	53	16	0.738	-0.089	3.999	0.01	0.007	0	42.6	37.4	76.5	133	118	0	34	31
2015	7	30	18	3	16	0.771	-0.085	3.999	0.013	0.01	0	43.9	38.7	67.1	136	121	0	34	31
2015	7	30	18	13	16	0.745	-0.092	3.999	0.01	0.007	0	43.4	37.8	77.4	135	120	0	34	32
2015	7	30	18	23	16	0.768	-0.112	3.999	0.01	0.007	0	43	38.3	77	134	120	0	34	31
2015	7	30	18	33	16	0.787	-0.108	3.999	0.01	0.007	0	43	38.3	77	134	120	0	34	31
2015	7	30	18	43	16	0.722	-0.098	3.999	0.01	0.007	0	43	37.8	75.3	134	120	0	34	32
2015	7	30	18	53	16	0.738	-0.102	3.999	0.013	0.01	0	43.4	37.8	64.5	135	120	0	34	32
2015	7	30	19	3	16	0.761	-0.092	3.999	0.013	0.01	0	43	37.8	67.5	134	120	0	34	32
2015	7	30	19	13	16	0.768	-0.102	3.999	0.01	0.007	0	43.4	37.8	74.8	135	120	0	34	32
2015	7	30	19	23	16	0.755	-0.075	3.999	0.01	0.007	0	42.6	38.3	77	134	120	0	35	31
2015	7	30	19	33	16	0.774	-0.079	3.999	0.01	0.007	0	42.6	38.3	75.3	134	120	0	35	31
2015	7	30	19	43	16	0.768	-0.066	3.999	0.01	0.007	0	43.9	38.3	76.1	135	120	0	33	31
2015	7	30	19	53	16	0.758	-0.098	3.999	0.013	0.01	0	43.4	38.3	74.4	134	120	0	33	31
2015	7	30	20	3	16	0.755	-0.079	3.999	0.01	0.007	0	43	37.4	74.4	134	119	0	34	32
2015	7	30	20	13	16	0.755	-0.089	4.003	0.01	0.007	0	43	37.8	75.7	134	119	0	34	31
2015	7	30	20	23	16	0.741	-0.095	4.003	0.01	0.007	0	43	37.8	77	134	120	0	34	32
2015	7	30	20	33	16	0.778	-0.102	4.003	0.013	0.01	0	43.4	38.3	76.1	135	120	0	34	31
2015	7	30	20	43	16	0.751	-0.112	3.999	0.013	0.01	0	43	38.3	73.5	135	121	0	35	32
2015	7	30	20	53	16	0.758	-0.095	3.999	0.01	0.007	0	43.4	38.3	75.7	135	120	0	34	31
2015	7	30	21	3	16	0.719	-0.072	4.003	0.01	0.007	0	43.4	37.8	77	135	120	0	34	32
2015	7	30	21	13	16	0.774	-0.079	4.003	0.013	0.01	0	43	38.3	76.5	134	120	0	34	31
2015	7	30	21	23	16	0.787	-0.112	4.003	0.013	0.01	0	43	37.4	77	134	119	0	34	32
2015	7	30	21	33	16	0.741	-0.098	4.003	0.01	0.007	0	43	37.4	75.7	134	119	0	34	32
2015	7	30	21	43	16	0.764	-0.062	4.003	0.013	0.01	0	43	38.3	76.1	134	120	0	34	31
2015	7	30	21	53	16	0.774	-0.112	4.003	0.013	0.01	0	42.6	37.4	77	133	118	0	34	31
2015	7	30	22	3	16	0.784	-0.075	4.003	0.01	0.007	0	43	37.8	77	134	119	0	34	31
2015	7	30	22	13	16	0.778	-0.098	4.003	0.01	0.007	0	43	37.4	75.3	134	119	0	34	32
2015	7	30	22	23	16	0.751	-0.059	4.003	0.016	0.013	0	43.4	38.3	76.1	135	120	0	34	31
2015	7	30	22	33	16	0.761	-0.069	4.003	0.013	0.01	0	43	37.4	76.5	134	119	0	34	32
2015	7	30	22	43	16	0.751	-0.098	4.003	0.01	0.007	0	43	37.8	76.5	134	119	0	34	31
2015	7	30	22	53	16	0.751	-0.098	4.003	0.016	0.013	0	43.4	37.8	76.5	135	119	0	34	31
2015	7	30	23	3	16	0.768	-0.079	4.003	0.01	0.007	0	43	37.8	76.5	135	120	0	35	32
2015	7	30	23	13	16	0.751	-0.112	4.003	0.01	0.007	0	42.6	37.4	76.5	133	119	0	34	32
2015	7	30	23	23	16	0.755	-0.092	4.003	0.013	0.01	0	43	37.4	76.5	134	119	0	34	32
2015	7	30	23	33	16	0.764	-0.105	4.003	0.013	0.01	0	42.6	37.4	76.5	134	119	0	35	32
2015	7	30	23	43	16	0.801	-0.108	4.003	0.013	0.01	0	42.6	37.4	76.5	133	118	0	34	31
2015	7	30	23	53	16	0.722	-0.085	4.003	0.01	0.007	0	42.6	37	76.5	133	118	0	34	32
2015	7	31	0	3	16	0.748	-0.072	4.003	0.01	0.007	0	42.6	37.4	76.5	133	118	0	34	31
2015	7	31	0	13	16	0.778	-0.098	4.003	0.01	0.007	0	42.6	37	77	133	118	0	34	32
2015	7	31	0	23	16	0.797	-0.112	4.003	0.016	0.013	0	42.6	37.8	77	133	118	0	34	30
2015	7	31	0	33	16	0.755	-0.108	4.003	0.013	0.01	0	42.1	37.4	77	133	119	0	35	32
2015	7	31	0	43	16	0.761	-0.102	4.003	0.01	0.007	0	42.6	37	75.7	133	118	0	34	32
2015	7	31	0	53	16	0.761	-0.118	4.003	0.01	0.007	0	42.1	37.4	77	133	118	0	35	31
2015	7	31	1	3	16	0.751	-0.089	4.003	0.01	0.007	0	42.6	37.4	77	133	118	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	31	1	13	16	0.758	-0.112	4.003	0.01	0.007	0	42.6	37.4	76.5	133	119	0	34	32
2015	7	31	1	23	16	0.741	-0.095	4.003	0.01	0.007	0	43	37.4	76.1	134	119	0	34	32
2015	7	31	1	33	16	0.787	-0.108	4.003	0.013	0.01	0	43	37	76.1	134	118	0	34	32
2015	7	31	1	43	16	0.764	-0.056	4.003	0.01	0.007	0	42.6	37.4	76.5	133	118	0	34	31
2015	7	31	1	53	16	0.751	-0.075	4.003	0.01	0.007	0	43	37.4	76.1	133	119	0	33	32
2015	7	31	2	3	16	0.768	-0.098	4.003	0.016	0.016	0	43	37.4	76.1	134	119	0	34	32
2015	7	31	2	13	16	0.732	-0.112	4.003	0.013	0.01	0	42.6	37	76.1	133	118	0	34	32
2015	7	31	2	23	16	0.791	-0.089	4.003	0.013	0.01	0	42.6	37.4	74.4	133	118	0	34	31
2015	7	31	2	33	16	0.778	-0.085	4.003	0.01	0.007	0	42.6	37.8	75.3	133	119	0	34	31
2015	7	31	2	43	16	0.741	-0.089	4.003	0.013	0.01	0	42.1	37.4	75.7	132	118	0	34	31
2015	7	31	2	53	16	0.751	-0.089	4.003	0.01	0.007	0	42.6	37	69.2	133	118	0	34	32
2015	7	31	3	3	16	0.768	-0.112	4.003	0.01	0.007	0	43	37.8	75.7	134	119	0	34	31
2015	7	31	3	13	16	0.761	-0.098	4.003	0.01	0.007	0	42.6	37.4	75.7	133	118	0	34	31
2015	7	31	3	23	16	0.774	-0.082	4.003	0.01	0.007	0	42.6	37	75.3	133	118	0	34	32
2015	7	31	3	33	16	0.781	-0.115	4.003	0.01	0.007	0	42.1	37	75.7	133	118	0	35	32
2015	7	31	3	43	16	0.768	-0.062	4.003	0.01	0.007	0	42.6	37	75.3	133	118	0	34	32
2015	7	31	3	53	16	0.728	-0.092	4.003	0.01	0.007	0	42.6	37.4	75.3	133	118	0	34	31
2015	7	31	4	3	16	0.774	-0.098	4.003	0.01	0.007	0	42.6	37	69.2	133	118	0	34	32
2015	7	31	4	13	16	0.751	-0.089	4.003	0.01	0.007	0	42.6	37.4	75.3	133	118	0	34	31
2015	7	31	4	23	16	0.781	-0.098	4.006	0.01	0.007	0	42.6	37.8	75.3	133	119	0	34	31
2015	7	31	4	33	16	0.778	-0.085	4.006	0.01	0.007	0	42.6	37	75.3	133	118	0	34	32
2015	7	31	4	43	16	0.764	-0.115	4.006	0.013	0.01	0	42.1	37.4	74.8	132	118	0	34	31
2015	7	31	4	53	16	0.797	-0.095	4.006	0.013	0.01	0	42.6	37	74	134	119	0	35	33
2015	7	31	5	3	16	0.745	-0.092	4.006	0.01	0.007	0	43	37.8	74.8	134	119	0	34	31
2015	7	31	5	13	16	0.787	-0.108	4.006	0.01	0.007	0	42.6	37.4	74.8	134	119	0	35	32
2015	7	31	5	23	16	0.778	-0.108	4.006	0.01	0.007	0	42.6	37.8	74.8	134	120	0	35	32
2015	7	31	5	33	16	0.735	-0.089	4.006	0.01	0.007	0	43	37.8	74.8	135	120	0	35	32
2015	7	31	5	43	16	0.748	-0.098	4.006	0.01	0.007	0	43.4	37.8	75.3	135	120	0	34	32
2015	7	31	5	53	16	0.781	-0.069	4.006	0.01	0.007	0	42.6	37.8	74	134	120	0	35	32
2015	7	31	6	3	16	0.797	-0.062	4.006	0.013	0.01	0	43.4	38.3	74	135	120	0	34	31
2015	7	31	6	13	16	0.722	-0.085	4.006	0.01	0.007	0	43.4	37.8	74	135	120	0	34	32
2015	7	31	6	23	16	0.764	-0.075	4.006	0.013	0.01	0	43.4	38.3	74.8	135	120	0	34	31
2015	7	31	6	33	16	0.764	-0.079	4.006	0.013	0.01	0	43.4	38.3	74.8	136	121	0	35	32
2015	7	31	6	43	16	0.771	-0.075	4.006	0.01	0.007	0	43.4	37.8	74.8	135	120	0	34	32
2015	7	31	6	53	16	0.722	-0.085	4.006	0.013	0.01	0	43	37.8	74.8	134	119	0	34	31
2015	7	31	7	3	16	0.771	-0.069	4.006	0.01	0.007	0	43	37.8	74.4	134	119	0	34	31
2015	7	31	7	13	16	0.764	-0.082	4.006	0.013	0.01	0	43	37.4	74.4	134	119	0	34	32
2015	7	31	7	23	16	0.758	-0.095	4.006	0.013	0.01	0	42.1	37	74.8	133	118	0	35	32
2015	7	31	7	33	16	0.761	-0.082	4.006	0.01	0.007	0	42.6	37	74	133	118	0	34	32
2015	7	31	7	43	16	0.751	-0.112	4.006	0.01	0.007	0	42.6	37.8	74.4	133	119	0	34	31
2015	7	31	7	53	16	0.745	-0.069	4.006	0.01	0.007	0	42.6	37.4	74.8	133	118	0	34	31
2015	7	31	8	3	16	0.774	-0.072	4.006	0.013	0.01	0	42.6	37	74.8	133	118	0	34	32
2015	7	31	8	13	16	0.778	-0.092	4.006	0.01	0.007	0	42.6	37.4	74	133	118	0	34	31
2015	7	31	8	23	16	0.761	-0.092	4.006	0.01	0.007	0	42.6	37.4	74	133	118	0	34	31
2015	7	31	8	33	16	0.764	-0.069	4.006	0.01	0.007	0	42.1	37	74.8	132	118	0	34	32
2015	7	31	8	43	16	0.741	-0.082	4.006	0.01	0.007	0	42.6	37.4	73.5	133	118	0	34	31
2015	7	31	8	53	16	0.735	-0.105	4.006	0.01	0.007	0	41.7	37	74	132	117	0	35	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	31	9	3	16	0.81	-0.079	4.006	0.01	0.007	0	41.7	37	74.4	132	118	0	35	32
2015	7	31	9	13	16	0.732	-0.098	4.006	0.01	0.007	0	42.1	36.5	74.8	132	117	0	34	32
2015	7	31	9	23	16	0.728	-0.052	4.006	0.01	0.007	0	42.1	37	74.8	132	118	0	34	32
2015	7	31	9	33	16	0.764	-0.092	4.006	0.01	0.007	0	41.7	37	74.4	132	117	0	35	31
2015	7	31	9	43	16	0.758	-0.066	4.006	0.01	0.007	0	42.1	36.5	74.8	132	117	0	34	32
2015	7	31	9	53	16	0.794	-0.079	4.006	0.016	0.013	0	42.1	37	74.4	132	117	0	34	31
2015	7	31	10	3	16	0.719	-0.095	4.006	0.013	0.01	0	41.7	36.5	74	131	117	0	34	32
2015	7	31	10	13	16	0.768	-0.082	4.006	0.013	0.01	0	41.3	37	75.7	131	117	0	35	31
2015	7	31	10	23	16	0.797	-0.089	4.006	0.016	0.013	0	41.7	36.5	75.7	131	116	0	34	31
2015	7	31	10	33	16	0.804	-0.085	4.006	0.01	0.007	0	41.3	36.5	75.7	131	116	0	35	31
2015	7	31	10	43	16	0.781	-0.062	4.006	0.013	0.01	0	41.7	36.5	73.1	131	117	0	34	32
2015	7	31	10	53	16	0.784	-0.072	4.006	0.01	0.007	0	42.1	37	75.7	132	117	0	34	31
2015	7	31	11	3	16	0.764	-0.105	4.006	0.013	0.01	0	42.1	36.5	75.3	132	117	0	34	32
2015	7	31	11	13	16	0.748	-0.098	4.006	0.01	0.007	0	41.7	36.5	75.7	132	117	0	35	32
2015	7	31	11	23	16	0.771	-0.082	4.006	0.013	0.01	0	41.7	37	76.1	132	118	0	35	32
2015	7	31	11	33	16	0.761	-0.112	4.006	0.013	0.01	0	41.7	37	76.1	132	118	0	35	32
2015	7	31	11	43	16	0.748	-0.066	4.003	0.013	0.01	0	42.1	37	76.1	132	117	0	34	31
2015	7	31	11	53	16	0.758	-0.066	4.003	0.013	0.01	0	41.7	36.5	76.1	131	117	0	34	32
2015	7	31	12	3	16	0.719	-0.033	4.003	0.01	0.007	0	41.7	36.1	76.5	131	116	0	34	32
2015	7	31	12	13	16	0.774	-0.105	4.003	0.01	0.007	0	41.7	37	76.1	131	117	0	34	31
2015	7	31	12	23	16	0.768	-0.112	4.003	0.013	0.01	0	41.7	37	75.7	131	117	0	34	31
2015	7	31	12	33	16	0.764	-0.105	4.003	0.01	0.007	0	41.3	37	75.7	131	117	0	35	31
2015	7	31	12	43	16	0.761	-0.075	4.003	0.013	0.01	0	41.3	36.5	76.5	131	116	0	35	31
2015	7	31	12	53	16	0.755	-0.092	4.003	0.013	0.01	0	41.3	36.5	77	131	116	0	35	31
2015	7	31	13	3	16	0.761	-0.102	4.003	0.013	0.01	0	41.7	37	76.5	131	117	0	34	31
2015	7	31	13	13	16	0.755	-0.082	4.003	0.01	0.007	0	41.7	36.5	76.5	131	116	0	34	31
2015	7	31	13	23	16	0.712	-0.075	4.003	0.01	0.007	0	41.3	36.1	75.7	130	116	0	34	32
2015	7	31	13	33	16	0.774	-0.112	4.003	0.01	0.007	0	41.7	36.5	76.1	131	117	0	34	32
2015	7	31	13	43	16	0.738	-0.085	4.003	0.01	0.007	0	42.1	37.4	77	132	118	0	34	31
2015	7	31	13	53	16	0.768	-0.075	4.003	0.013	0.01	0	41.7	37	77	131	117	0	34	31
2015	7	31	14	3	16	0.764	-0.095	4.003	0.01	0.007	0	41.7	36.5	77	131	116	0	34	31
2015	7	31	14	13	16	0.761	-0.102	4.003	0.01	0.007	0	41.7	36.5	77	131	116	0	34	31
2015	7	31	14	23	16	0.741	-0.089	4.003	0.01	0.007	0	41.7	37	76.1	131	117	0	34	31
2015	7	31	14	33	16	0.755	-0.098	4.003	0.016	0.013	0	41.7	36.1	77.4	131	116	0	34	32
2015	7	31	14	43	16	0.768	-0.098	4.003	0.013	0.01	0	41.3	36.1	77	130	115	0	34	31
2015	7	31	14	53	16	0.758	-0.098	4.003	0.01	0.007	0	41.7	36.1	76.5	131	116	0	34	32
2015	7	31	15	3	16	0.735	-0.069	4.003	0.01	0.007	0	42.1	37	76.5	132	117	0	34	31
2015	7	31	15	13	16	0.768	-0.098	4.003	0.013	0.01	0	41.3	36.1	76.5	130	116	0	34	32
2015	7	31	15	23	16	0.771	-0.072	4.003	0.01	0.007	0	41.7	36.1	77.8	131	116	0	34	32
2015	7	31	15	33	16	0.784	-0.075	4.003	0.01	0.007	0	41.3	36.5	77.8	130	116	0	34	31
2015	7	31	15	43	16	0.738	-0.069	3.999	0.013	0.01	0	41.7	36.1	77.4	131	116	0	34	32
2015	7	31	15	53	16	0.741	-0.121	3.999	0.016	0.013	0	40.9	36.5	77.4	130	116	0	35	31
2015	7	31	16	3	16	0.771	-0.082	3.999	0.01	0.007	0	41.7	36.5	77	131	116	0	34	31
2015	7	31	16	13	16	0.692	-0.095	3.999	0.01	0.007	0	41.7	36.5	77	131	116	0	34	31
2015	7	31	16	23	16	0.751	-0.098	3.999	0.013	0.01	0	42.1	37.4	77.4	132	118	0	34	31
2015	7	31	16	33	16	0.751	-0.066	3.999	0.01	0.007	0	41.7	36.1	77.4	131	116	0	34	32
2015	7	31	16	43	16	0.768	-0.085	3.999	0.013	0.01	0	41.7	37	76.5	131	117	0	34	31

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	VelocityX	VelocityY	Level	StdError1	StdError2	StdError3	SNR1	SNR2	SNR3	SignalAmp1	SignalAmp2	SignalAmp3	Noise1	Noise2
2015	7	31	16	53	16	0.771	-0.098	3.999	0.01	0.007	0	41.3	36.1	77.4	130	115	0	34	31
2015	7	31	17	3	16	0.787	-0.082	3.999	0.01	0.007	0	41.3	36.5	75.7	130	116	0	34	31
2015	7	31	17	13	16	0.778	-0.069	3.999	0.01	0.007	0	41.7	36.5	76.5	131	116	0	34	31
2015	7	31	17	23	16	0.791	-0.062	3.999	0.01	0.007	0	41.7	36.5	76.1	131	117	0	34	32
2015	7	31	17	33	16	0.741	-0.079	3.996	0.01	0.007	0	41.3	36.5	76.5	130	116	0	34	31
2015	7	31	17	43	16	0.778	-0.115	3.996	0.01	0.007	0	40.9	36.5	76.1	130	116	0	35	31
2015	7	31	17	53	16	0.741	-0.072	3.996	0.01	0.007	0	41.7	36.1	77	131	116	0	34	32
2015	7	31	18	3	16	0.748	-0.082	3.996	0.016	0.013	0	41.7	36.5	76.5	131	117	0	34	32
2015	7	31	18	13	16	0.787	-0.066	3.996	0.01	0.007	0	41.7	37	75.7	132	117	0	35	31
2015	7	31	18	23	16	0.755	-0.098	3.996	0.01	0.007	0	41.7	37	76.1	131	117	0	34	31
2015	7	31	18	33	16	0.738	-0.108	3.996	0.01	0.007	0	40.9	36.1	76.1	130	116	0	35	32
2015	7	31	18	43	16	0.741	-0.098	3.996	0.01	0.007	0	41.7	36.5	75.7	131	116	0	34	31
2015	7	31	18	53	16	0.738	-0.089	3.996	0.013	0.01	0	41.3	36.5	75.3	131	116	0	35	31
2015	7	31	19	3	16	0.741	-0.082	3.996	0.013	0.01	0	41.7	36.5	76.1	131	116	0	34	31
2015	7	31	19	13	16	0.738	-0.115	3.996	0.01	0.007	0	42.1	37	75.7	132	117	0	34	31
2015	7	31	19	23	16	0.784	-0.062	3.996	0.01	0.007	0	41.7	37	75.7	131	117	0	34	31
2015	7	31	19	33	16	0.781	-0.112	3.996	0.013	0.01	0	42.1	37	76.1	132	117	0	34	31
2015	7	31	19	43	16	0.748	-0.079	3.996	0.01	0.007	0	42.1	37	76.1	132	118	0	34	32
2015	7	31	19	53	16	0.755	-0.079	3.996	0.013	0.01	0	42.6	37.4	74.8	133	118	0	34	31
2015	7	31	20	3	16	0.728	-0.102	3.996	0.01	0.007	0	42.1	37.4	75.3	132	118	0	34	31
2015	7	31	20	13	16	0.778	-0.098	3.996	0.01	0.007	0	42.1	37	75.3	132	118	0	34	32
2015	7	31	20	23	16	0.755	-0.082	3.996	0.01	0.007	0	42.6	37.4	75.3	133	118	0	34	31
2015	7	31	20	33	16	0.732	-0.098	3.996	0.013	0.01	0	42.6	37.4	74.4	133	119	0	34	32
2015	7	31	20	43	16	0.787	-0.089	3.996	0.013	0.01	0	42.6	37.4	74	133	118	0	34	31
2015	7	31	20	53	16	0.751	-0.082	3.996	0.013	0.01	0	42.6	37.4	75.7	133	118	0	34	31
2015	7	31	21	3	16	0.771	-0.082	3.996	0.01	0.007	0	42.1	37	76.1	132	118	0	34	32
2015	7	31	21	13	16	0.748	-0.089	3.996	0.013	0.01	0	42.1	37	75.7	132	118	0	34	32
2015	7	31	21	23	16	0.771	-0.072	3.996	0.01	0.007	0	42.1	37.4	76.1	132	118	0	34	31
2015	7	31	21	33	16	0.748	-0.066	3.996	0.01	0.007	0	42.1	37	76.1	132	118	0	34	32
2015	7	31	21	43	16	0.755	-0.082	3.996	0.01	0.007	0	42.1	37.4	76.1	132	118	0	34	31
2015	7	31	21	53	16	0.761	-0.108	3.996	0.013	0.01	0	42.1	37.4	76.5	132	118	0	34	31
2015	7	31	22	3	16	0.748	-0.121	3.996	0.013	0.01	0	42.1	37.4	76.1	132	118	0	34	31
2015	7	31	22	13	16	0.791	-0.098	3.996	0.016	0.013	0	41.7	37.4	76.1	132	118	0	35	31
2015	7	31	22	23	16	0.751	-0.069	3.996	0.01	0.007	0	42.1	37.4	76.5	132	118	0	34	31
2015	7	31	22	33	16	0.755	-0.085	3.996	0.013	0.01	0	42.1	37	76.5	132	118	0	34	32
2015	7	31	22	43	16	0.794	-0.108	3.996	0.01	0.007	0	42.1	37	77	132	118	0	34	32
2015	7	31	22	53	16	0.751	-0.075	3.996	0.01	0.007	0	42.1	37.4	75.7	132	118	0	34	31
2015	7	31	23	3	16	0.771	-0.092	3.996	0.01	0.007	0	42.6	37.4	77	133	118	0	34	31
2015	7	31	23	13	16	0.771	-0.082	3.996	0.013	0.01	0	42.6	37.4	77.4	133	119	0	34	32
2015	7	31	23	23	16	0.748	-0.072	3.999	0.013	0.01	0	42.6	37.4	77.4	133	118	0	34	31
2015	7	31	23	33	16	0.787	-0.069	3.999	0.013	0.01	0	42.6	37.4	77.4	133	118	0	34	31
2015	7	31	23	43	16	0.755	-0.066	3.999	0.013	0.01	0	42.1	37.8	77	133	119	0	35	31
2015	7	31	23	53	16	0.794	-0.079	3.999	0.01	0.007	0	42.6	37.4	77	133	119	0	34	32

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	1	0	3	6	31	0	0	0	0	0	0	0	70.79	0	0	12
2015	7	1	0	13	6	32	0	0	0	0	0	0	0	70.74	0	0	12
2015	7	1	0	23	6	32	0	0	0	0	0	0	0	70.7	0	0	12
2015	7	1	0	33	6	31	0	0	0	0	0	0	0	70.65	0	0	11.8
2015	7	1	0	43	6	32	0	0	0	0	0	0	0	70.61	0	0	11.8
2015	7	1	0	53	6	32	0	0	0	0	0	0	0	70.57	0	0	11.8
2015	7	1	1	3	6	32	0	0	0	0	0	0	0	70.52	0	0	11.8
2015	7	1	1	13	6	32	0	0	0	0	0	0	0	70.48	0	0	11.8
2015	7	1	1	23	6	32	0	0	0	0	0	0	0	70.43	0	0	11.8
2015	7	1	1	33	6	32	0	0	0	0	0	0	0	70.38	0	0	11.8
2015	7	1	1	43	6	33	0	0	0	0	0	0	0	70.34	0	0	11.8
2015	7	1	1	53	6	32	0	0	0	0	0	0	0	70.29	0	0	11.8
2015	7	1	2	3	6	31	0	0	0	0	0	0	0	70.25	0	0	11.8
2015	7	1	2	13	6	32	0	0	0	0	0	0	0	70.2	0	0	11.8
2015	7	1	2	23	6	32	0	0	0	0	0	0	0	70.16	0	0	11.8
2015	7	1	2	33	6	32	0	0	0	0	0	0	0	70.12	0	0	11.8
2015	7	1	2	43	6	32	0	0	0	0	0	0	0	70.09	0	0	11.8
2015	7	1	2	53	6	32	0	0	0	0	0	0	0	70.05	0	0	11.8
2015	7	1	3	3	6	32	0	0	0	0	0	0	0	70.02	0	0	11.8
2015	7	1	3	13	6	32	0	0	0	0	0	0	0	69.98	0	0	11.8
2015	7	1	3	23	6	32	0	0	0	0	0	0	0	69.94	0	0	11.8
2015	7	1	3	33	6	32	0	0	0	0	0	0	0	69.91	0	0	11.8
2015	7	1	3	43	6	32	0	0	0	0	0	0	0	69.87	0	0	11.8
2015	7	1	3	53	6	32	0	0	0	0	0	0	0	69.84	0	0	11.8
2015	7	1	4	3	6	32	0	0	0	0	0	0	0	69.8	0	0	11.8
2015	7	1	4	13	6	32	0	0	0	0	0	0	0	69.76	0	0	11.8
2015	7	1	4	23	6	31	0	0	0	0	0	0	0	69.71	0	0	11.8
2015	7	1	4	33	6	32	0	0	0	0	0	0	0	69.67	0	0	11.8
2015	7	1	4	43	6	32	0	0	0	0	0	0	0	69.64	0	0	11.8
2015	7	1	4	53	6	32	0	0	0	0	0	0	0	69.6	0	0	11.8
2015	7	1	5	3	6	32	0	0	0	0	0	0	0	69.57	0	0	11.8
2015	7	1	5	13	6	32	0	0	0	0	0	0	0	69.53	0	0	11.8
2015	7	1	5	23	6	33	0	0	0	0	0	0	0	69.49	0	0	11.8
2015	7	1	5	33	6	31	0	0	0	0	0	0	0	69.46	0	0	11.8
2015	7	1	5	43	6	32	0	0	0	0	0	0	0	69.42	0	0	11.8
2015	7	1	5	53	6	32	0	0	0	0	0	0	0	69.37	0	0	11.8
2015	7	1	6	3	6	32	0	0	0	0	0	0	0	69.33	0	0	11.8
2015	7	1	6	13	6	33	0	0	0	0	0	0	0	69.28	0	0	11.8
2015	7	1	6	23	6	32	0	0	0	0	0	0	0	69.24	0	0	11.8
2015	7	1	6	33	6	32	0	0	0	0	0	0	0	69.21	0	0	11.8
2015	7	1	6	43	6	32	0	0	0	0	0	0	0	69.19	0	0	11.8
2015	7	1	6	53	6	33	0	0	0	0	0	0	0	69.15	0	0	11.8
2015	7	1	7	3	6	32	0	0	0	0	0	0	0	69.13	0	0	11.8
2015	7	1	7	13	6	32	0	0	0	0	0	0	0	69.12	0	0	11.8
2015	7	1	7	23	6	32	0	0	0	0	0	0	0	69.1	0	0	11.8
2015	7	1	7	33	6	32	0	0	0	0	0	0	0	69.08	0	0	11.8
2015	7	1	7	43	6	32	0	0	0	0	0	0	0	69.04	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	1	7	53	6	32	0	0	0	0	0	0	0	69.03	0	0	11.8
2015	7	1	8	3	6	32	0	0	0	0	0	0	0	69.01	0	0	11.8
2015	7	1	8	13	6	32	0	0	0	0	0	0	0	68.99	0	0	11.8
2015	7	1	8	23	6	33	0	0	0	0	0	0	0	68.99	0	0	11.8
2015	7	1	8	33	6	32	0	0	0	0	0	0	0	68.97	0	0	11.8
2015	7	1	8	43	6	31	0	0	0	0	0	0	0	68.95	0	0	11.8
2015	7	1	8	53	6	32	0	0	0	0	0	0	0	68.95	0	0	11.8
2015	7	1	9	3	6	32	0	0	0	0	0	0	0	68.95	0	0	11.8
2015	7	1	9	13	6	32	0	0	0	0	0	0	0	68.92	0	0	11.8
2015	7	1	9	23	6	32	0	0	0	0	0	0	0	68.9	0	0	11.8
2015	7	1	9	33	6	32	0	0	0	0	0	0	0	68.9	0	0	11.8
2015	7	1	9	43	6	32	0	0	0	0	0	0	0	68.92	0	0	11.8
2015	7	1	9	53	6	32	0	0	0	0	0	0	0	68.9	0	0	11.8
2015	7	1	10	3	6	33	0	0	0	0	0	0	0	68.94	0	0	12
2015	7	1	10	13	6	33	0	0	0	0	0	0	0	68.94	0	0	11.8
2015	7	1	10	23	6	32	0	0	0	0	0	0	0	68.92	0	0	11.8
2015	7	1	10	33	6	33	0	0	0	0	0	0	0	68.9	0	0	11.8
2015	7	1	10	43	6	32	0	0	0	0	0	0	0	68.9	0	0	11.8
2015	7	1	10	53	6	32	0	0	0	0	0	0	0	68.9	0	0	11.8
2015	7	1	11	3	6	32	0	0	0	0	0	0	0	68.92	0	0	12
2015	7	1	11	13	6	33	0	0	0	0	0	0	0	68.99	0	0	12
2015	7	1	11	23	6	32	0	0	0	0	0	0	0	68.99	0	0	12.2
2015	7	1	11	33	6	32	0	0	0	0	0	0	0	69.03	0	0	12.2
2015	7	1	11	43	6	32	0	0	0	0	0	0	0	69.03	0	0	12.2
2015	7	1	11	53	6	32	0	0	0	0	0	0	0	69.04	0	0	12.2
2015	7	1	12	3	6	32	0	0	0	0	0	0	0	69.06	0	0	12.2
2015	7	1	12	13	6	32	0	0	0	0	0	0	0	69.13	0	0	12.4
2015	7	1	12	23	6	32	0	0	0	0	0	0	0	69.22	0	0	12.6
2015	7	1	12	33	6	32	0	0	0	0	0	0	0	69.4	0	0	12.8
2015	7	1	12	43	6	33	0	0	0	0	0	0	0	69.42	0	0	12.6
2015	7	1	12	53	6	32	0	0	0	0	0	0	0	69.3	0	0	12.4
2015	7	1	13	3	6	32	0	0	0	0	0	0	0	69.3	0	0	12.4
2015	7	1	13	13	6	32	0	0	0	0	0	0	0	69.33	0	0	12.4
2015	7	1	13	23	6	32	0	0	0	0	0	0	0	69.48	0	0	13.2
2015	7	1	13	33	6	32	0	0	0	0	0	0	0	69.67	0	0	14.2
2015	7	1	13	43	6	32	0	0	0	0	0	0	0	69.75	0	0	14
2015	7	1	13	53	6	32	0	0	0	0	0	0	0	69.85	0	0	13
2015	7	1	14	3	6	32	0	0	0	0	0	0	0	69.93	0	0	13
2015	7	1	14	13	6	32	0	0	0	0	0	0	0	69.96	0	0	13
2015	7	1	14	23	6	32	0	0	0	0	0	0	0	70	0	0	13.4
2015	7	1	14	33	6	32	0	0	0	0	0	0	0	69.78	0	0	12.8
2015	7	1	14	43	6	32	0	0	0	0	0	0	0	69.82	0	0	13
2015	7	1	14	53	6	32	0	0	0	0	0	0	0	70.02	0	0	13.6
2015	7	1	15	3	6	33	0	0	0	0	0	0	0	69.91	0	0	13.2
2015	7	1	15	13	6	32	0	0	0	0	0	0	0	69.94	0	0	13.4
2015	7	1	15	23	6	32	0	0	0	0	0	0	0	70.03	0	0	13.6
2015	7	1	15	33	6	32	0	0	0	0	0	0	0	69.96	0	0	12.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	1	15	43	6	32		0	0	0	0	0	0	70.05	0	0	12.6
2015	7	1	15	53	6	32		0	0	0	0	0	0	70.03	0	0	12.6
2015	7	1	16	3	6	32		0	0	0	0	0	0	70.05	0	0	12.6
2015	7	1	16	13	6	32		0	0	0	0	0	0	70.11	0	0	12.6
2015	7	1	16	23	6	32		0	0	0	0	0	0	70.16	0	0	12.6
2015	7	1	16	33	6	32		0	0	0	0	0	0	70.18	0	0	12.6
2015	7	1	16	43	6	32		0	0	0	0	0	0	70.2	0	0	12.6
2015	7	1	16	53	6	33		0	0	0	0	0	0	70.23	0	0	12.4
2015	7	1	17	3	6	32		0	0	0	0	0	0	70.23	0	0	12.4
2015	7	1	17	13	6	31		0	0	0	0	0	0	70.21	0	0	12.4
2015	7	1	17	23	6	32		0	0	0	0	0	0	70.21	0	0	12.4
2015	7	1	17	33	6	32		0	0	0	0	0	0	70.25	0	0	12.2
2015	7	1	17	43	6	31		0	0	0	0	0	0	70.23	0	0	12.2
2015	7	1	17	53	6	32		0	0	0	0	0	0	70.25	0	0	12.2
2015	7	1	18	3	6	32		0	0	0	0	0	0	70.25	0	0	12.2
2015	7	1	18	13	6	32		0	0	0	0	0	0	70.27	0	0	12.2
2015	7	1	18	23	6	32		0	0	0	0	0	0	70.29	0	0	12
2015	7	1	18	33	6	33		0	0	0	0	0	0	70.3	0	0	12
2015	7	1	18	43	6	32		0	0	0	0	0	0	70.3	0	0	12
2015	7	1	18	53	6	32		0	0	0	0	0	0	70.32	0	0	12
2015	7	1	19	3	6	32		0	0	0	0	0	0	70.34	0	0	12
2015	7	1	19	13	6	33		0	0	0	0	0	0	70.34	0	0	12
2015	7	1	19	23	6	32		0	0	0	0	0	0	70.34	0	0	12
2015	7	1	19	33	6	32		0	0	0	0	0	0	70.34	0	0	12
2015	7	1	19	43	6	32		0	0	0	0	0	0	70.34	0	0	12
2015	7	1	19	53	6	32		0	0	0	0	0	0	70.34	0	0	12
2015	7	1	20	3	6	32		0	0	0	0	0	0	70.34	0	0	12
2015	7	1	20	13	6	32		0	0	0	0	0	0	70.34	0	0	12
2015	7	1	20	23	6	32		0	0	0	0	0	0	70.32	0	0	12
2015	7	1	20	33	6	32		0	0	0	0	0	0	70.32	0	0	12
2015	7	1	20	43	6	32		0	0	0	0	0	0	70.3	0	0	12
2015	7	1	20	53	6	32		0	0	0	0	0	0	70.3	0	0	12
2015	7	1	21	3	6	32		0	0	0	0	0	0	70.29	0	0	12
2015	7	1	21	13	6	32		0	0	0	0	0	0	70.29	0	0	12
2015	7	1	21	23	6	32		0	0	0	0	0	0	70.27	0	0	12
2015	7	1	21	33	6	32		0	0	0	0	0	0	70.25	0	0	12
2015	7	1	21	43	6	32		0	0	0	0	0	0	70.25	0	0	12
2015	7	1	21	53	6	32		0	0	0	0	0	0	70.23	0	0	12
2015	7	1	22	3	6	32		0	0	0	0	0	0	70.21	0	0	12
2015	7	1	22	13	6	32		0	0	0	0	0	0	70.2	0	0	12
2015	7	1	22	23	6	32		0	0	0	0	0	0	70.18	0	0	12
2015	7	1	22	33	6	31		0	0	0	0	0	0	70.16	0	0	11.8
2015	7	1	22	43	6	32		0	0	0	0	0	0	70.14	0	0	11.8
2015	7	1	22	53	6	32		0	0	0	0	0	0	70.11	0	0	11.8
2015	7	1	23	3	6	32		0	0	0	0	0	0	70.09	0	0	11.8
2015	7	1	23	13	6	32		0	0	0	0	0	0	70.09	0	0	11.8
2015	7	1	23	23	6	32		0	0	0	0	0	0	70.05	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	1	23	33	6	32	0	0	0	0	0	0	0	70.03	0	0	11.8
2015	7	1	23	43	6	32	0	0	0	0	0	0	0	70.02	0	0	11.8
2015	7	1	23	53	6	32	0	0	0	0	0	0	0	70	0	0	11.8
2015	7	2	0	3	6	31	0	0	0	0	0	0	0	69.98	0	0	11.8
2015	7	2	0	13	6	32	0	0	0	0	0	0	0	69.96	0	0	11.8
2015	7	2	0	23	6	32	0	0	0	0	0	0	0	69.94	0	0	11.8
2015	7	2	0	33	6	32	0	0	0	0	0	0	0	69.93	0	0	11.8
2015	7	2	0	43	6	32	0	0	0	0	0	0	0	69.91	0	0	11.8
2015	7	2	0	53	6	32	0	0	0	0	0	0	0	69.89	0	0	11.8
2015	7	2	1	3	6	32	0	0	0	0	0	0	0	69.87	0	0	11.8
2015	7	2	1	13	6	32	0	0	0	0	0	0	0	69.87	0	0	11.8
2015	7	2	1	23	6	32	0	0	0	0	0	0	0	69.85	0	0	11.8
2015	7	2	1	33	6	32	0	0	0	0	0	0	0	69.84	0	0	11.8
2015	7	2	1	43	6	32	0	0	0	0	0	0	0	69.84	0	0	11.8
2015	7	2	1	53	6	32	0	0	0	0	0	0	0	69.82	0	0	11.8
2015	7	2	2	3	6	32	0	0	0	0	0	0	0	69.8	0	0	11.8
2015	7	2	2	13	6	32	0	0	0	0	0	0	0	69.8	0	0	11.8
2015	7	2	2	23	6	33	0	0	0	0	0	0	0	69.78	0	0	11.8
2015	7	2	2	33	6	31	0	0	0	0	0	0	0	69.76	0	0	11.8
2015	7	2	2	43	6	32	0	0	0	0	0	0	0	69.76	0	0	11.8
2015	7	2	2	53	6	32	0	0	0	0	0	0	0	69.75	0	0	11.8
2015	7	2	3	3	6	32	0	0	0	0	0	0	0	69.73	0	0	11.8
2015	7	2	3	13	6	33	0	0	0	0	0	0	0	69.73	0	0	11.8
2015	7	2	3	23	6	32	0	0	0	0	0	0	0	69.71	0	0	11.8
2015	7	2	3	33	6	32	0	0	0	0	0	0	0	69.69	0	0	11.8
2015	7	2	3	43	6	32	0	0	0	0	0	0	0	69.69	0	0	11.8
2015	7	2	3	53	6	32	0	0	0	0	0	0	0	69.67	0	0	11.8
2015	7	2	4	3	6	32	0	0	0	0	0	0	0	69.67	0	0	11.8
2015	7	2	4	13	6	32	0	0	0	0	0	0	0	69.66	0	0	11.8
2015	7	2	4	23	6	32	0	0	0	0	0	0	0	69.64	0	0	11.8
2015	7	2	4	33	6	33	0	0	0	0	0	0	0	69.62	0	0	11.8
2015	7	2	4	43	6	31	0	0	0	0	0	0	0	69.6	0	0	11.8
2015	7	2	4	53	6	32	0	0	0	0	0	0	0	69.6	0	0	11.8
2015	7	2	5	3	6	32	0	0	0	0	0	0	0	69.58	0	0	11.8
2015	7	2	5	13	6	33	0	0	0	0	0	0	0	69.57	0	0	11.8
2015	7	2	5	23	6	32	0	0	0	0	0	0	0	69.55	0	0	11.8
2015	7	2	5	33	6	32	0	0	0	0	0	0	0	69.53	0	0	11.8
2015	7	2	5	43	6	32	0	0	0	0	0	0	0	69.53	0	0	11.8
2015	7	2	5	53	6	33	0	0	0	0	0	0	0	69.51	0	0	11.8
2015	7	2	6	3	6	32	0	0	0	0	0	0	0	69.49	0	0	11.8
2015	7	2	6	13	6	32	0	0	0	0	0	0	0	69.49	0	0	11.8
2015	7	2	6	23	6	32	0	0	0	0	0	0	0	69.49	0	0	11.8
2015	7	2	6	33	6	32	0	0	0	0	0	0	0	69.49	0	0	11.8
2015	7	2	6	43	6	32	0	0	0	0	0	0	0	69.48	0	0	11.8
2015	7	2	6	53	6	32	0	0	0	0	0	0	0	69.48	0	0	11.8
2015	7	2	7	3	6	33	0	0	0	0	0	0	0	69.49	0	0	11.8
2015	7	2	7	13	6	33	0	0	0	0	0	0	0	69.48	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	2	7	23	6	32		0	0	0	0	0	0	69.49	0	0	12
2015	7	2	7	33	6	33		0	0	0	0	0	0	69.49	0	0	12
2015	7	2	7	43	6	32		0	0	0	0	0	0	69.53	0	0	12
2015	7	2	7	53	6	32		0	0	0	0	0	0	69.53	0	0	12
2015	7	2	8	3	6	32		0	0	0	0	0	0	69.53	0	0	12
2015	7	2	8	13	6	33		0	0	0	0	0	0	69.55	0	0	12
2015	7	2	8	23	6	32		0	0	0	0	0	0	69.55	0	0	12
2015	7	2	8	33	6	32		0	0	0	0	0	0	69.53	0	0	12
2015	7	2	8	43	6	32		0	0	0	0	0	0	69.55	0	0	12
2015	7	2	8	53	6	33		0	0	0	0	0	0	69.53	0	0	12
2015	7	2	9	3	6	32		0	0	0	0	0	0	69.55	0	0	12
2015	7	2	9	13	6	32		0	0	0	0	0	0	69.55	0	0	12
2015	7	2	9	23	6	32		0	0	0	0	0	0	69.58	0	0	12
2015	7	2	9	33	6	31		0	0	0	0	0	0	69.62	0	0	12
2015	7	2	9	43	6	32		0	0	0	0	0	0	69.67	0	0	12.2
2015	7	2	9	53	6	32		0	0	0	0	0	0	69.69	0	0	12.2
2015	7	2	10	3	6	33		0	0	0	0	0	0	69.67	0	0	12.2
2015	7	2	10	13	6	32		0	0	0	0	0	0	69.69	0	0	12.2
2015	7	2	10	23	6	31		0	0	0	0	0	0	69.73	0	0	12.2
2015	7	2	10	33	6	32		0	0	0	0	0	0	69.76	0	0	12.2
2015	7	2	10	43	6	32		0	0	0	0	0	0	69.76	0	0	12.2
2015	7	2	10	53	6	32		0	0	0	0	0	0	69.78	0	0	12.2
2015	7	2	11	3	6	32		0	0	0	0	0	0	69.82	0	0	12.2
2015	7	2	11	13	6	32		0	0	0	0	0	0	69.87	0	0	12.2
2015	7	2	11	23	6	32		0	0	0	0	0	0	69.89	0	0	12.4
2015	7	2	11	33	6	32		0	0	0	0	0	0	69.91	0	0	12.4
2015	7	2	11	43	6	32		0	0	0	0	0	0	69.98	0	0	12.6
2015	7	2	11	53	6	32		0	0	0	0	0	0	70.11	0	0	13
2015	7	2	12	3	6	31		0	0	0	0	0	0	70.16	0	0	13.6
2015	7	2	12	13	6	33		0	0	0	0	0	0	70.25	0	0	13.4
2015	7	2	12	23	6	33		0	0	0	0	0	0	70.29	0	0	13.6
2015	7	2	12	33	6	32		0	0	0	0	0	0	70.25	0	0	13.4
2015	7	2	12	43	6	32		0	0	0	0	0	0	70.27	0	0	13.4
2015	7	2	12	53	6	31		0	0	0	0	0	0	70.43	0	0	13.4
2015	7	2	13	3	6	33		0	0	0	0	0	0	70.41	0	0	13.4
2015	7	2	13	13	6	32		0	0	0	0	0	0	70.52	0	0	13.2
2015	7	2	13	23	6	32		0	0	0	0	0	0	70.38	0	0	13
2015	7	2	13	33	6	32		0	0	0	0	0	0	70.36	0	0	12.6
2015	7	2	13	43	6	32		0	0	0	0	0	0	70.36	0	0	12.8
2015	7	2	13	53	6	32		0	0	0	0	0	0	70.66	0	0	13.4
2015	7	2	14	3	6	32		0	0	0	0	0	0	70.77	0	0	13
2015	7	2	14	13	6	32		0	0	0	0	0	0	70.56	0	0	12.6
2015	7	2	14	23	6	32		0	0	0	0	0	0	70.54	0	0	13
2015	7	2	14	33	6	33		0	0	0	0	0	0	70.9	0	0	13.8
2015	7	2	14	43	6	31		0	0	0	0	0	0	71.02	0	0	13.4
2015	7	2	14	53	6	31		0	0	0	0	0	0	70.79	0	0	13
2015	7	2	15	3	6	31		0	0	0	0	0	0	70.92	0	0	13.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	2	15	13	6	32		0	0	0	0	0	0	71.02	0	0	13.2
2015	7	2	15	23	6	32		0	0	0	0	0	0	70.99	0	0	13.2
2015	7	2	15	33	6	32		0	0	0	0	0	0	71.11	0	0	13.2
2015	7	2	15	43	6	33		0	0	0	0	0	0	71.1	0	0	13
2015	7	2	15	53	6	32		0	0	0	0	0	0	71.11	0	0	13
2015	7	2	16	3	6	32		0	0	0	0	0	0	71.13	0	0	13
2015	7	2	16	13	6	33		0	0	0	0	0	0	71.17	0	0	13
2015	7	2	16	23	6	32		0	0	0	0	0	0	71.19	0	0	13
2015	7	2	16	33	6	32		0	0	0	0	0	0	71.19	0	0	12.8
2015	7	2	16	43	6	32		0	0	0	0	0	0	71.22	0	0	12.8
2015	7	2	16	53	6	32		0	0	0	0	0	0	71.2	0	0	12.8
2015	7	2	17	3	6	32		0	0	0	0	0	0	71.13	0	0	12.4
2015	7	2	17	13	6	32		0	0	0	0	0	0	71.17	0	0	12.6
2015	7	2	17	23	6	32		0	0	0	0	0	0	71.15	0	0	12.4
2015	7	2	17	33	6	32		0	0	0	0	0	0	71.19	0	0	12.4
2015	7	2	17	43	6	32		0	0	0	0	0	0	71.15	0	0	12.2
2015	7	2	17	53	6	32		0	0	0	0	0	0	71.15	0	0	12
2015	7	2	18	3	6	31		0	0	0	0	0	0	71.15	0	0	11.8
2015	7	2	18	13	6	32		0	0	0	0	0	0	71.15	0	0	11.8
2015	7	2	18	23	6	32		0	0	0	0	0	0	71.15	0	0	11.6
2015	7	2	18	33	6	32		0	0	0	0	0	0	71.19	0	0	12
2015	7	2	18	43	6	32		0	0	0	0	0	0	71.19	0	0	12
2015	7	2	18	53	6	32		0	0	0	0	0	0	71.17	0	0	12
2015	7	2	19	3	6	32		0	0	0	0	0	0	71.17	0	0	12
2015	7	2	19	13	6	32		0	0	0	0	0	0	71.19	0	0	12
2015	7	2	19	23	6	32		0	0	0	0	0	0	71.19	0	0	12
2015	7	2	19	33	6	32		0	0	0	0	0	0	71.19	0	0	12
2015	7	2	19	43	6	31		0	0	0	0	0	0	71.19	0	0	12
2015	7	2	19	53	6	32		0	0	0	0	0	0	71.19	0	0	12
2015	7	2	20	3	6	32		0	0	0	0	0	0	71.19	0	0	12
2015	7	2	20	13	6	32		0	0	0	0	0	0	71.19	0	0	12
2015	7	2	20	23	6	32		0	0	0	0	0	0	71.17	0	0	12
2015	7	2	20	33	6	32		0	0	0	0	0	0	71.17	0	0	12
2015	7	2	20	43	6	32		0	0	0	0	0	0	71.17	0	0	12
2015	7	2	20	53	6	31		0	0	0	0	0	0	71.15	0	0	11.8
2015	7	2	21	3	6	32		0	0	0	0	0	0	71.13	0	0	11.8
2015	7	2	21	13	6	32		0	0	0	0	0	0	71.11	0	0	11.8
2015	7	2	21	23	6	32		0	0	0	0	0	0	71.1	0	0	11.8
2015	7	2	21	33	6	32		0	0	0	0	0	0	71.08	0	0	11.8
2015	7	2	21	43	6	31		0	0	0	0	0	0	71.06	0	0	11.8
2015	7	2	21	53	6	31		0	0	0	0	0	0	71.04	0	0	11.8
2015	7	2	22	3	6	32		0	0	0	0	0	0	71.02	0	0	11.8
2015	7	2	22	13	6	31		0	0	0	0	0	0	70.99	0	0	11.8
2015	7	2	22	23	6	32		0	0	0	0	0	0	70.97	0	0	11.8
2015	7	2	22	33	6	32		0	0	0	0	0	0	70.93	0	0	11.8
2015	7	2	22	43	6	32		0	0	0	0	0	0	70.92	0	0	11.8
2015	7	2	22	53	6	31		0	0	0	0	0	0	70.88	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	2	23	3	6	33	0	0	0	0	0	0	0	70.83	0	0	11.8
2015	7	2	23	13	6	32	0	0	0	0	0	0	0	70.81	0	0	11.8
2015	7	2	23	23	6	32	0	0	0	0	0	0	0	70.77	0	0	11.8
2015	7	2	23	33	6	32	0	0	0	0	0	0	0	70.74	0	0	11.8
2015	7	2	23	43	6	32	0	0	0	0	0	0	0	70.7	0	0	11.8
2015	7	2	23	53	6	32	0	0	0	0	0	0	0	70.68	0	0	11.8
2015	7	3	0	3	6	32	0	0	0	0	0	0	0	70.65	0	0	11.8
2015	7	3	0	13	6	32	0	0	0	0	0	0	0	70.65	0	0	11.8
2015	7	3	0	23	6	32	0	0	0	0	0	0	0	70.61	0	0	11.8
2015	7	3	0	33	6	31	0	0	0	0	0	0	0	70.59	0	0	11.8
2015	7	3	0	43	6	32	0	0	0	0	0	0	0	70.59	0	0	11.8
2015	7	3	0	53	6	32	0	0	0	0	0	0	0	70.57	0	0	11.8
2015	7	3	1	3	6	32	0	0	0	0	0	0	0	70.56	0	0	11.8
2015	7	3	1	13	6	33	0	0	0	0	0	0	0	70.56	0	0	11.8
2015	7	3	1	23	6	31	0	0	0	0	0	0	0	70.54	0	0	11.8
2015	7	3	1	33	6	31	0	0	0	0	0	0	0	70.52	0	0	11.8
2015	7	3	1	43	6	32	0	0	0	0	0	0	0	70.52	0	0	11.8
2015	7	3	1	53	6	32	0	0	0	0	0	0	0	70.5	0	0	11.8
2015	7	3	2	3	6	31	0	0	0	0	0	0	0	70.5	0	0	11.8
2015	7	3	2	13	6	32	0	0	0	0	0	0	0	70.5	0	0	11.8
2015	7	3	2	23	6	32	0	0	0	0	0	0	0	70.48	0	0	11.8
2015	7	3	2	33	6	32	0	0	0	0	0	0	0	70.5	0	0	11.8
2015	7	3	2	43	6	32	0	0	0	0	0	0	0	70.5	0	0	11.8
2015	7	3	2	53	6	32	0	0	0	0	0	0	0	70.5	0	0	11.8
2015	7	3	3	3	6	32	0	0	0	0	0	0	0	70.5	0	0	11.8
2015	7	3	3	13	6	32	0	0	0	0	0	0	0	70.5	0	0	11.8
2015	7	3	3	23	6	32	0	0	0	0	0	0	0	70.5	0	0	11.8
2015	7	3	3	33	6	32	0	0	0	0	0	0	0	70.5	0	0	11.8
2015	7	3	3	43	6	32	0	0	0	0	0	0	0	70.5	0	0	11.8
2015	7	3	3	53	6	31	0	0	0	0	0	0	0	70.5	0	0	11.8
2015	7	3	4	3	6	32	0	0	0	0	0	0	0	70.5	0	0	11.8
2015	7	3	4	13	6	32	0	0	0	0	0	0	0	70.5	0	0	11.8
2015	7	3	4	23	6	33	0	0	0	0	0	0	0	70.5	0	0	11.8
2015	7	3	4	33	6	32	0	0	0	0	0	0	0	70.5	0	0	11.8
2015	7	3	4	43	6	33	0	0	0	0	0	0	0	70.5	0	0	11.8
2015	7	3	4	53	6	32	0	0	0	0	0	0	0	70.48	0	0	11.8
2015	7	3	5	3	6	32	0	0	0	0	0	0	0	70.48	0	0	11.8
2015	7	3	5	13	6	32	0	0	0	0	0	0	0	70.47	0	0	11.8
2015	7	3	5	23	6	32	0	0	0	0	0	0	0	70.45	0	0	11.8
2015	7	3	5	33	6	32	0	0	0	0	0	0	0	70.45	0	0	11.8
2015	7	3	5	43	6	32	0	0	0	0	0	0	0	70.43	0	0	11.8
2015	7	3	5	53	6	32	0	0	0	0	0	0	0	70.41	0	0	11.8
2015	7	3	6	3	6	32	0	0	0	0	0	0	0	70.39	0	0	11.8
2015	7	3	6	13	6	32	0	0	0	0	0	0	0	70.38	0	0	11.8
2015	7	3	6	23	6	32	0	0	0	0	0	0	0	70.36	0	0	11.8
2015	7	3	6	33	6	32	0	0	0	0	0	0	0	70.34	0	0	11.8
2015	7	3	6	43	6	32	0	0	0	0	0	0	0	70.32	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	3	6	53	6	32	0	0	0	0	0	0	0	70.3	0	0	11.8
2015	7	3	7	3	6	32	0	0	0	0	0	0	0	70.29	0	0	12
2015	7	3	7	13	6	32	0	0	0	0	0	0	0	70.27	0	0	12
2015	7	3	7	23	6	32	0	0	0	0	0	0	0	70.29	0	0	12
2015	7	3	7	33	6	31	0	0	0	0	0	0	0	70.29	0	0	12
2015	7	3	7	43	6	32	0	0	0	0	0	0	0	70.29	0	0	12
2015	7	3	7	53	6	32	0	0	0	0	0	0	0	70.29	0	0	12.2
2015	7	3	8	3	6	31	0	0	0	0	0	0	0	70.3	0	0	12.2
2015	7	3	8	13	6	32	0	0	0	0	0	0	0	70.32	0	0	12.2
2015	7	3	8	23	6	32	0	0	0	0	0	0	0	70.32	0	0	12.4
2015	7	3	8	33	6	32	0	0	0	0	0	0	0	70.34	0	0	12.4
2015	7	3	8	43	6	32	0	0	0	0	0	0	0	70.36	0	0	12.4
2015	7	3	8	53	6	32	0	0	0	0	0	0	0	70.38	0	0	12.4
2015	7	3	9	3	6	32	0	0	0	0	0	0	0	70.41	0	0	12.4
2015	7	3	9	13	6	32	0	0	0	0	0	0	0	70.45	0	0	12.4
2015	7	3	9	23	6	32	0	0	0	0	0	0	0	70.47	0	0	12.4
2015	7	3	9	33	6	32	0	0	0	0	0	0	0	70.48	0	0	12.4
2015	7	3	9	43	6	31	0	0	0	0	0	0	0	70.54	0	0	12.6
2015	7	3	9	53	6	32	0	0	0	0	0	0	0	70.59	0	0	12.6
2015	7	3	10	3	6	32	0	0	0	0	0	0	0	70.63	0	0	12.6
2015	7	3	10	13	6	32	0	0	0	0	0	0	0	70.66	0	0	12.4
2015	7	3	10	23	6	32	0	0	0	0	0	0	0	70.74	0	0	12.6
2015	7	3	10	33	6	32	0	0	0	0	0	0	0	70.75	0	0	12.6
2015	7	3	10	43	6	32	0	0	0	0	0	0	0	70.83	0	0	12.6
2015	7	3	10	53	6	32	0	0	0	0	0	0	0	70.86	0	0	12.6
2015	7	3	11	3	6	31	0	0	0	0	0	0	0	70.92	0	0	12.6
2015	7	3	11	13	6	32	0	0	0	0	0	0	0	70.99	0	0	12.6
2015	7	3	11	23	6	32	0	0	0	0	0	0	0	71.04	0	0	12.6
2015	7	3	11	33	6	32	0	0	0	0	0	0	0	71.1	0	0	12.6
2015	7	3	11	43	6	32	0	0	0	0	0	0	0	71.15	0	0	12.6
2015	7	3	11	53	6	32	0	0	0	0	0	0	0	71.2	0	0	12.6
2015	7	3	12	3	6	32	0	0	0	0	0	0	0	71.28	0	0	12.8
2015	7	3	12	13	6	32	0	0	0	0	0	0	0	71.35	0	0	12.8
2015	7	3	12	23	6	32	0	0	0	0	0	0	0	71.38	0	0	12.8
2015	7	3	12	33	6	32	0	0	0	0	0	0	0	71.42	0	0	12.6
2015	7	3	12	43	6	32	0	0	0	0	0	0	0	71.51	0	0	12.8
2015	7	3	12	53	6	32	0	0	0	0	0	0	0	71.55	0	0	12.8
2015	7	3	13	3	6	32	0	0	0	0	0	0	0	71.58	0	0	12.8
2015	7	3	13	13	6	31	0	0	0	0	0	0	0	71.65	0	0	12.8
2015	7	3	13	23	6	32	0	0	0	0	0	0	0	71.71	0	0	12.6
2015	7	3	13	33	6	31	0	0	0	0	0	0	0	71.76	0	0	13
2015	7	3	13	43	6	31	0	0	0	0	0	0	0	71.8	0	0	13
2015	7	3	13	53	6	32	0	0	0	0	0	0	0	71.87	0	0	13
2015	7	3	14	3	6	32	0	0	0	0	0	0	0	71.89	0	0	12.8
2015	7	3	14	13	6	33	0	0	0	0	0	0	0	71.89	0	0	12.8
2015	7	3	14	23	6	32	0	0	0	0	0	0	0	71.94	0	0	12.6
2015	7	3	14	33	6	32	0	0	0	0	0	0	0	71.98	0	0	12.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	3	14	43	6	32		0	0	0	0	0	0	71.96	0	0	12.8
2015	7	3	14	53	6	31		0	0	0	0	0	0	72.01	0	0	12.8
2015	7	3	15	3	6	32		0	0	0	0	0	0	72.1	0	0	13
2015	7	3	15	13	6	31		0	0	0	0	0	0	72.12	0	0	13
2015	7	3	15	23	6	32		0	0	0	0	0	0	72.09	0	0	12.8
2015	7	3	15	33	6	31		0	0	0	0	0	0	72.19	0	0	12.8
2015	7	3	15	43	6	33		0	0	0	0	0	0	72.14	0	0	12.6
2015	7	3	15	53	6	32		0	0	0	0	0	0	72.18	0	0	12.8
2015	7	3	16	3	6	32		0	0	0	0	0	0	72.23	0	0	12.8
2015	7	3	16	13	6	32		0	0	0	0	0	0	72.3	0	0	12.8
2015	7	3	16	23	6	32		0	0	0	0	0	0	72.21	0	0	12.4
2015	7	3	16	33	6	32		0	0	0	0	0	0	72.16	0	0	12.4
2015	7	3	16	43	6	31		0	0	0	0	0	0	72.14	0	0	12.4
2015	7	3	16	53	6	31		0	0	0	0	0	0	72.14	0	0	12.4
2015	7	3	17	3	6	32		0	0	0	0	0	0	72.12	0	0	12.2
2015	7	3	17	13	6	31		0	0	0	0	0	0	72.12	0	0	12.2
2015	7	3	17	23	6	32		0	0	0	0	0	0	72.12	0	0	12.2
2015	7	3	17	33	6	32		0	0	0	0	0	0	72.12	0	0	12.2
2015	7	3	17	43	6	31		0	0	0	0	0	0	72.1	0	0	12.2
2015	7	3	17	53	6	32		0	0	0	0	0	0	72.1	0	0	12.2
2015	7	3	18	3	6	31		0	0	0	0	0	0	72.1	0	0	12.2
2015	7	3	18	13	6	32		0	0	0	0	0	0	72.09	0	0	12.2
2015	7	3	18	23	6	32		0	0	0	0	0	0	72.07	0	0	12
2015	7	3	18	33	6	31		0	0	0	0	0	0	72.07	0	0	12
2015	7	3	18	43	6	32		0	0	0	0	0	0	72.05	0	0	12
2015	7	3	18	53	6	32		0	0	0	0	0	0	72.03	0	0	12
2015	7	3	19	3	6	31		0	0	0	0	0	0	72.03	0	0	12
2015	7	3	19	13	6	32		0	0	0	0	0	0	72.01	0	0	12
2015	7	3	19	23	6	31		0	0	0	0	0	0	72	0	0	12
2015	7	3	19	33	6	31		0	0	0	0	0	0	71.98	0	0	12
2015	7	3	19	43	6	32		0	0	0	0	0	0	71.98	0	0	12
2015	7	3	19	53	6	32		0	0	0	0	0	0	71.96	0	0	12
2015	7	3	20	3	6	32		0	0	0	0	0	0	71.94	0	0	12
2015	7	3	20	13	6	32		0	0	0	0	0	0	71.91	0	0	12
2015	7	3	20	23	6	32		0	0	0	0	0	0	71.89	0	0	12
2015	7	3	20	33	6	32		0	0	0	0	0	0	71.87	0	0	12
2015	7	3	20	43	6	32		0	0	0	0	0	0	71.83	0	0	12
2015	7	3	20	53	6	32		0	0	0	0	0	0	71.82	0	0	12
2015	7	3	21	3	6	31		0	0	0	0	0	0	71.78	0	0	12
2015	7	3	21	13	6	32		0	0	0	0	0	0	71.76	0	0	12
2015	7	3	21	23	6	33		0	0	0	0	0	0	71.73	0	0	12
2015	7	3	21	33	6	32		0	0	0	0	0	0	71.71	0	0	12
2015	7	3	21	43	6	32		0	0	0	0	0	0	71.67	0	0	12
2015	7	3	21	53	6	32		0	0	0	0	0	0	71.65	0	0	12
2015	7	3	22	3	6	32		0	0	0	0	0	0	71.62	0	0	12
2015	7	3	22	13	6	32		0	0	0	0	0	0	71.6	0	0	12
2015	7	3	22	23	6	31		0	0	0	0	0	0	71.56	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	3	22	33	6	32		0	0	0	0	0	0	71.55	0	0	12
2015	7	3	22	43	6	33		0	0	0	0	0	0	71.53	0	0	12
2015	7	3	22	53	6	32		0	0	0	0	0	0	71.49	0	0	12
2015	7	3	23	3	6	32		0	0	0	0	0	0	71.47	0	0	12
2015	7	3	23	13	6	32		0	0	0	0	0	0	71.46	0	0	12
2015	7	3	23	23	6	32		0	0	0	0	0	0	71.42	0	0	12
2015	7	3	23	33	6	32		0	0	0	0	0	0	71.4	0	0	12
2015	7	3	23	43	6	32		0	0	0	0	0	0	71.4	0	0	12
2015	7	3	23	53	6	32		0	0	0	0	0	0	71.38	0	0	12
2015	7	4	0	3	6	32		0	0	0	0	0	0	71.37	0	0	12
2015	7	4	0	13	6	32		0	0	0	0	0	0	71.35	0	0	12
2015	7	4	0	23	6	32		0	0	0	0	0	0	71.35	0	0	12
2015	7	4	0	33	6	31		0	0	0	0	0	0	71.33	0	0	12
2015	7	4	0	43	6	32		0	0	0	0	0	0	71.33	0	0	12
2015	7	4	0	53	6	32		0	0	0	0	0	0	71.31	0	0	12
2015	7	4	1	3	6	31		0	0	0	0	0	0	71.31	0	0	12
2015	7	4	1	13	6	33		0	0	0	0	0	0	71.29	0	0	12
2015	7	4	1	23	6	31		0	0	0	0	0	0	71.28	0	0	11.8
2015	7	4	1	33	6	33		0	0	0	0	0	0	71.28	0	0	11.8
2015	7	4	1	43	6	32		0	0	0	0	0	0	71.28	0	0	11.8
2015	7	4	1	53	6	32		0	0	0	0	0	0	71.26	0	0	11.8
2015	7	4	2	3	6	32		0	0	0	0	0	0	71.26	0	0	11.8
2015	7	4	2	13	6	32		0	0	0	0	0	0	71.26	0	0	11.8
2015	7	4	2	23	6	32		0	0	0	0	0	0	71.24	0	0	11.8
2015	7	4	2	33	6	32		0	0	0	0	0	0	71.22	0	0	11.8
2015	7	4	2	43	6	32		0	0	0	0	0	0	71.2	0	0	11.8
2015	7	4	2	53	6	32		0	0	0	0	0	0	71.19	0	0	11.8
2015	7	4	3	3	6	33		0	0	0	0	0	0	71.17	0	0	11.8
2015	7	4	3	13	6	32		0	0	0	0	0	0	71.15	0	0	11.8
2015	7	4	3	23	6	33		0	0	0	0	0	0	71.13	0	0	11.8
2015	7	4	3	33	6	32		0	0	0	0	0	0	71.11	0	0	11.8
2015	7	4	3	43	6	32		0	0	0	0	0	0	71.1	0	0	11.8
2015	7	4	3	53	6	32		0	0	0	0	0	0	71.08	0	0	11.8
2015	7	4	4	3	6	32		0	0	0	0	0	0	71.06	0	0	11.8
2015	7	4	4	13	6	31		0	0	0	0	0	0	71.04	0	0	11.8
2015	7	4	4	23	6	32		0	0	0	0	0	0	71.02	0	0	11.8
2015	7	4	4	33	6	32		0	0	0	0	0	0	70.99	0	0	11.8
2015	7	4	4	43	6	33		0	0	0	0	0	0	70.95	0	0	11.8
2015	7	4	4	53	6	32		0	0	0	0	0	0	70.93	0	0	11.8
2015	7	4	5	3	6	32		0	0	0	0	0	0	70.92	0	0	11.8
2015	7	4	5	13	6	32		0	0	0	0	0	0	70.88	0	0	11.8
2015	7	4	5	23	6	32		0	0	0	0	0	0	70.86	0	0	11.8
2015	7	4	5	33	6	32		0	0	0	0	0	0	70.83	0	0	11.8
2015	7	4	5	43	6	31		0	0	0	0	0	0	70.79	0	0	11.8
2015	7	4	5	53	6	32		0	0	0	0	0	0	70.75	0	0	11.8
2015	7	4	6	3	6	31		0	0	0	0	0	0	70.74	0	0	11.8
2015	7	4	6	13	6	32		0	0	0	0	0	0	70.72	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	4	6	23	6	32		0	0	0	0	0	0	70.68	0	0	11.8
2015	7	4	6	33	6	32		0	0	0	0	0	0	70.66	0	0	11.8
2015	7	4	6	43	6	32		0	0	0	0	0	0	70.63	0	0	11.8
2015	7	4	6	53	6	32		0	0	0	0	0	0	70.59	0	0	11.8
2015	7	4	7	3	6	32		0	0	0	0	0	0	70.57	0	0	11.8
2015	7	4	7	13	6	32		0	0	0	0	0	0	70.52	0	0	11.8
2015	7	4	7	23	6	32		0	0	0	0	0	0	70.5	0	0	11.8
2015	7	4	7	33	6	31		0	0	0	0	0	0	70.48	0	0	11.8
2015	7	4	7	43	6	32		0	0	0	0	0	0	70.45	0	0	11.8
2015	7	4	7	53	6	32		0	0	0	0	0	0	70.43	0	0	11.8
2015	7	4	8	3	6	32		0	0	0	0	0	0	70.43	0	0	12
2015	7	4	8	13	6	32		0	0	0	0	0	0	70.43	0	0	12
2015	7	4	8	23	6	32		0	0	0	0	0	0	70.45	0	0	12.2
2015	7	4	8	33	6	32		0	0	0	0	0	0	70.43	0	0	12.2
2015	7	4	8	43	6	32		0	0	0	0	0	0	70.43	0	0	12
2015	7	4	8	53	6	32		0	0	0	0	0	0	70.41	0	0	12
2015	7	4	9	3	6	32		0	0	0	0	0	0	70.39	0	0	12
2015	7	4	9	13	6	31		0	0	0	0	0	0	70.39	0	0	12.2
2015	7	4	9	23	6	32		0	0	0	0	0	0	70.41	0	0	12.2
2015	7	4	9	33	6	32		0	0	0	0	0	0	70.45	0	0	12.4
2015	7	4	9	43	6	32		0	0	0	0	0	0	70.41	0	0	12.2
2015	7	4	9	53	6	32		0	0	0	0	0	0	70.54	0	0	12.6
2015	7	4	10	3	6	32		0	0	0	0	0	0	70.47	0	0	12.4
2015	7	4	10	13	6	32		0	0	0	0	0	0	70.48	0	0	12.4
2015	7	4	10	23	6	32		0	0	0	0	0	0	70.47	0	0	12.2
2015	7	4	10	33	6	32		0	0	0	0	0	0	70.66	0	0	13
2015	7	4	10	43	6	32		0	0	0	0	0	0	70.63	0	0	13.2
2015	7	4	10	53	6	32		0	0	0	0	0	0	70.74	0	0	13
2015	7	4	11	3	6	32		0	0	0	0	0	0	70.9	0	0	13.2
2015	7	4	11	13	6	33		0	0	0	0	0	0	70.92	0	0	13
2015	7	4	11	23	6	32		0	0	0	0	0	0	70.81	0	0	12.6
2015	7	4	11	33	6	33		0	0	0	0	0	0	70.81	0	0	12.8
2015	7	4	11	43	6	31		0	0	0	0	0	0	70.81	0	0	13
2015	7	4	11	53	6	32		0	0	0	0	0	0	70.81	0	0	12.6
2015	7	4	12	3	6	31		0	0	0	0	0	0	70.84	0	0	12.6
2015	7	4	12	13	6	32		0	0	0	0	0	0	71.01	0	0	13
2015	7	4	12	23	6	32		0	0	0	0	0	0	71.13	0	0	13
2015	7	4	12	33	6	32		0	0	0	0	0	0	71.22	0	0	13
2015	7	4	12	43	6	32		0	0	0	0	0	0	71.06	0	0	13
2015	7	4	12	53	6	32		0	0	0	0	0	0	71.24	0	0	13
2015	7	4	13	3	6	32		0	0	0	0	0	0	71.15	0	0	13
2015	7	4	13	13	6	31		0	0	0	0	0	0	71.33	0	0	13
2015	7	4	13	23	6	32		0	0	0	0	0	0	71.44	0	0	13
2015	7	4	13	33	6	32		0	0	0	0	0	0	71.33	0	0	12.8
2015	7	4	13	43	6	32		0	0	0	0	0	0	71.4	0	0	12.6
2015	7	4	13	53	6	31		0	0	0	0	0	0	71.38	0	0	12.6
2015	7	4	14	3	6	32		0	0	0	0	0	0	71.35	0	0	12.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	4	14	13	6	32		0	0	0	0	0	0	71.35	0	0	12.8
2015	7	4	14	23	6	32		0	0	0	0	0	0	71.37	0	0	12.8
2015	7	4	14	33	6	31		0	0	0	0	0	0	71.4	0	0	12.8
2015	7	4	14	43	6	32		0	0	0	0	0	0	71.64	0	0	13
2015	7	4	14	53	6	31		0	0	0	0	0	0	71.76	0	0	12.8
2015	7	4	15	3	6	32		0	0	0	0	0	0	71.62	0	0	12.6
2015	7	4	15	13	6	32		0	0	0	0	0	0	71.6	0	0	12.4
2015	7	4	15	23	6	32		0	0	0	0	0	0	71.6	0	0	12.4
2015	7	4	15	33	6	31		0	0	0	0	0	0	71.62	0	0	12.2
2015	7	4	15	43	6	32		0	0	0	0	0	0	71.71	0	0	12.8
2015	7	4	15	53	6	31		0	0	0	0	0	0	71.65	0	0	12.6
2015	7	4	16	3	6	32		0	0	0	0	0	0	71.65	0	0	12.6
2015	7	4	16	13	6	31		0	0	0	0	0	0	71.69	0	0	12.6
2015	7	4	16	23	6	32		0	0	0	0	0	0	71.65	0	0	12.2
2015	7	4	16	33	6	32		0	0	0	0	0	0	71.64	0	0	12.2
2015	7	4	16	43	6	31		0	0	0	0	0	0	71.64	0	0	12.2
2015	7	4	16	53	6	31		0	0	0	0	0	0	71.64	0	0	12.2
2015	7	4	17	3	6	32		0	0	0	0	0	0	71.62	0	0	12.2
2015	7	4	17	13	6	31		0	0	0	0	0	0	71.6	0	0	12
2015	7	4	17	23	6	32		0	0	0	0	0	0	71.6	0	0	12
2015	7	4	17	33	6	31		0	0	0	0	0	0	71.58	0	0	11.4
2015	7	4	17	43	6	31		0	0	0	0	0	0	71.58	0	0	11.4
2015	7	4	17	53	6	32		0	0	0	0	0	0	71.55	0	0	11.4
2015	7	4	18	3	6	32		0	0	0	0	0	0	71.53	0	0	11.4
2015	7	4	18	13	6	32		0	0	0	0	0	0	71.51	0	0	11.4
2015	7	4	18	23	6	31		0	0	0	0	0	0	71.49	0	0	11.4
2015	7	4	18	33	6	32		0	0	0	0	0	0	71.47	0	0	12
2015	7	4	18	43	6	32		0	0	0	0	0	0	71.44	0	0	12
2015	7	4	18	53	6	32		0	0	0	0	0	0	71.4	0	0	12
2015	7	4	19	3	6	32		0	0	0	0	0	0	71.38	0	0	12
2015	7	4	19	13	6	32		0	0	0	0	0	0	71.37	0	0	12
2015	7	4	19	23	6	32		0	0	0	0	0	0	71.35	0	0	12
2015	7	4	19	33	6	32		0	0	0	0	0	0	71.33	0	0	12
2015	7	4	19	43	6	32		0	0	0	0	0	0	71.29	0	0	12
2015	7	4	19	53	6	31		0	0	0	0	0	0	71.28	0	0	12
2015	7	4	20	3	6	32		0	0	0	0	0	0	71.26	0	0	12
2015	7	4	20	13	6	32		0	0	0	0	0	0	71.24	0	0	12
2015	7	4	20	23	6	31		0	0	0	0	0	0	71.2	0	0	12
2015	7	4	20	33	6	32		0	0	0	0	0	0	71.19	0	0	12
2015	7	4	20	43	6	31		0	0	0	0	0	0	71.15	0	0	12
2015	7	4	20	53	6	31		0	0	0	0	0	0	71.13	0	0	12
2015	7	4	21	3	6	32		0	0	0	0	0	0	71.11	0	0	12
2015	7	4	21	13	6	32		0	0	0	0	0	0	71.1	0	0	12
2015	7	4	21	23	6	32		0	0	0	0	0	0	71.06	0	0	12
2015	7	4	21	33	6	32		0	0	0	0	0	0	71.04	0	0	12
2015	7	4	21	43	6	32		0	0	0	0	0	0	71.02	0	0	11.8
2015	7	4	21	53	6	32		0	0	0	0	0	0	71.01	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	4	22	3	6	32	0	0	0	0	0	0	0	70.97	0	0	11.8
2015	7	4	22	13	6	31	0	0	0	0	0	0	0	70.95	0	0	11.8
2015	7	4	22	23	6	32	0	0	0	0	0	0	0	70.92	0	0	11.8
2015	7	4	22	33	6	32	0	0	0	0	0	0	0	70.9	0	0	11.8
2015	7	4	22	43	6	33	0	0	0	0	0	0	0	70.86	0	0	11.8
2015	7	4	22	53	6	32	0	0	0	0	0	0	0	70.84	0	0	11.8
2015	7	4	23	3	6	32	0	0	0	0	0	0	0	70.83	0	0	11.8
2015	7	4	23	13	6	32	0	0	0	0	0	0	0	70.79	0	0	11.8
2015	7	4	23	23	6	32	0	0	0	0	0	0	0	70.77	0	0	11.8
2015	7	4	23	33	6	32	0	0	0	0	0	0	0	70.75	0	0	11.8
2015	7	4	23	43	6	32	0	0	0	0	0	0	0	70.72	0	0	11.8
2015	7	4	23	53	6	32	0	0	0	0	0	0	0	70.7	0	0	11.8
2015	7	5	0	3	6	32	0	0	0	0	0	0	0	70.66	0	0	11.8
2015	7	5	0	13	6	32	0	0	0	0	0	0	0	70.65	0	0	11.8
2015	7	5	0	23	6	32	0	0	0	0	0	0	0	70.63	0	0	11.8
2015	7	5	0	33	6	32	0	0	0	0	0	0	0	70.59	0	0	11.8
2015	7	5	0	43	6	32	0	0	0	0	0	0	0	70.56	0	0	11.8
2015	7	5	0	53	6	32	0	0	0	0	0	0	0	70.52	0	0	11.8
2015	7	5	1	3	6	32	0	0	0	0	0	0	0	70.48	0	0	11.8
2015	7	5	1	13	6	31	0	0	0	0	0	0	0	70.45	0	0	11.8
2015	7	5	1	23	6	32	0	0	0	0	0	0	0	70.43	0	0	11.8
2015	7	5	1	33	6	32	0	0	0	0	0	0	0	70.39	0	0	11.8
2015	7	5	1	43	6	32	0	0	0	0	0	0	0	70.36	0	0	11.8
2015	7	5	1	53	6	32	0	0	0	0	0	0	0	70.32	0	0	11.8
2015	7	5	2	3	6	32	0	0	0	0	0	0	0	70.29	0	0	11.8
2015	7	5	2	13	6	32	0	0	0	0	0	0	0	70.25	0	0	11.8
2015	7	5	2	23	6	32	0	0	0	0	0	0	0	70.21	0	0	11.8
2015	7	5	2	33	6	32	0	0	0	0	0	0	0	70.18	0	0	11.8
2015	7	5	2	43	6	32	0	0	0	0	0	0	0	70.14	0	0	11.8
2015	7	5	2	53	6	31	0	0	0	0	0	0	0	70.11	0	0	11.8
2015	7	5	3	3	6	32	0	0	0	0	0	0	0	70.07	0	0	11.8
2015	7	5	3	13	6	31	0	0	0	0	0	0	0	70.02	0	0	11.8
2015	7	5	3	23	6	32	0	0	0	0	0	0	0	69.98	0	0	11.8
2015	7	5	3	33	6	32	0	0	0	0	0	0	0	69.94	0	0	11.8
2015	7	5	3	43	6	32	0	0	0	0	0	0	0	69.89	0	0	11.8
2015	7	5	3	53	6	32	0	0	0	0	0	0	0	69.84	0	0	11.8
2015	7	5	4	3	6	32	0	0	0	0	0	0	0	69.8	0	0	11.8
2015	7	5	4	13	6	31	0	0	0	0	0	0	0	69.76	0	0	11.8
2015	7	5	4	23	6	33	0	0	0	0	0	0	0	69.71	0	0	11.8
2015	7	5	4	33	6	32	0	0	0	0	0	0	0	69.67	0	0	10.8
2015	7	5	4	43	6	31	0	0	0	0	0	0	0	69.62	0	0	10.8
2015	7	5	4	53	6	32	0	0	0	0	0	0	0	69.57	0	0	10.8
2015	7	5	5	3	6	32	0	0	0	0	0	0	0	69.53	0	0	10.6
2015	7	5	5	13	6	31	0	0	0	0	0	0	0	69.48	0	0	10.6
2015	7	5	5	23	6	33	0	0	0	0	0	0	0	69.42	0	0	10.6
2015	7	5	5	33	6	32	0	0	0	0	0	0	0	69.37	0	0	11
2015	7	5	5	43	6	32	0	0	0	0	0	0	0	69.33	0	0	11

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	5	5	53	6	32	0	0	0	0	0	0	0	69.28	0	0	11
2015	7	5	6	3	6	32	0	0	0	0	0	0	0	69.24	0	0	11
2015	7	5	6	13	6	32	0	0	0	0	0	0	0	69.19	0	0	11
2015	7	5	6	23	6	32	0	0	0	0	0	0	0	69.13	0	0	11
2015	7	5	6	33	6	32	0	0	0	0	0	0	0	69.08	0	0	11.2
2015	7	5	6	43	6	31	0	0	0	0	0	0	0	69.04	0	0	11.6
2015	7	5	6	53	6	31	0	0	0	0	0	0	0	68.99	0	0	11.6
2015	7	5	7	3	6	32	0	0	0	0	0	0	0	68.94	0	0	11.8
2015	7	5	7	13	6	33	0	0	0	0	0	0	0	68.9	0	0	12
2015	7	5	7	23	6	32	0	0	0	0	0	0	0	68.9	0	0	12.4
2015	7	5	7	33	6	32	0	0	0	0	0	0	0	68.88	0	0	13
2015	7	5	7	43	6	32	0	0	0	0	0	0	0	68.86	0	0	13.4
2015	7	5	7	53	6	32	0	0	0	0	0	0	0	68.86	0	0	13.2
2015	7	5	8	3	6	32	0	0	0	0	0	0	0	68.86	0	0	13.4
2015	7	5	8	13	6	32	0	0	0	0	0	0	0	68.86	0	0	13.4
2015	7	5	8	23	6	32	0	0	0	0	0	0	0	68.86	0	0	13.4
2015	7	5	8	33	6	32	0	0	0	0	0	0	0	68.86	0	0	12.6
2015	7	5	8	43	6	32	0	0	0	0	0	0	0	68.88	0	0	12.6
2015	7	5	8	53	6	32	0	0	0	0	0	0	0	68.9	0	0	12.6
2015	7	5	9	3	6	32	0	0	0	0	0	0	0	68.92	0	0	12.6
2015	7	5	9	13	6	32	0	0	0	0	0	0	0	68.94	0	0	12.6
2015	7	5	9	23	6	32	0	0	0	0	0	0	0	68.95	0	0	13.4
2015	7	5	9	33	6	33	0	0	0	0	0	0	0	69.01	0	0	13.4
2015	7	5	9	43	6	32	0	0	0	0	0	0	0	69.04	0	0	13.4
2015	7	5	9	53	6	32	0	0	0	0	0	0	0	69.1	0	0	13.4
2015	7	5	10	3	6	33	0	0	0	0	0	0	0	69.15	0	0	13.6
2015	7	5	10	13	6	33	0	0	0	0	0	0	0	69.19	0	0	12.8
2015	7	5	10	23	6	32	0	0	0	0	0	0	0	69.24	0	0	12.6
2015	7	5	10	33	6	32	0	0	0	0	0	0	0	69.31	0	0	12.6
2015	7	5	10	43	6	32	0	0	0	0	0	0	0	69.37	0	0	12.6
2015	7	5	10	53	6	32	0	0	0	0	0	0	0	69.42	0	0	12.6
2015	7	5	11	3	6	32	0	0	0	0	0	0	0	69.48	0	0	12.8
2015	7	5	11	13	6	32	0	0	0	0	0	0	0	69.53	0	0	12.6
2015	7	5	11	23	6	32	0	0	0	0	0	0	0	69.58	0	0	12.6
2015	7	5	11	33	6	32	0	0	0	0	0	0	0	69.66	0	0	12.8
2015	7	5	11	43	6	32	0	0	0	0	0	0	0	69.71	0	0	12.6
2015	7	5	11	53	6	32	0	0	0	0	0	0	0	69.78	0	0	12.6
2015	7	5	12	3	6	32	0	0	0	0	0	0	0	69.85	0	0	12.8
2015	7	5	12	13	6	32	0	0	0	0	0	0	0	69.89	0	0	12.8
2015	7	5	12	23	6	32	0	0	0	0	0	0	0	69.98	0	0	13
2015	7	5	12	33	6	32	0	0	0	0	0	0	0	70.03	0	0	12.8
2015	7	5	12	43	6	32	0	0	0	0	0	0	0	70.11	0	0	12.8
2015	7	5	12	53	6	32	0	0	0	0	0	0	0	70.23	0	0	12.8
2015	7	5	13	3	6	32	0	0	0	0	0	0	0	70.23	0	0	12.6
2015	7	5	13	13	6	32	0	0	0	0	0	0	0	70.02	0	0	12.6
2015	7	5	13	23	6	32	0	0	0	0	0	0	0	69.98	0	0	12.4
2015	7	5	13	33	6	32	0	0	0	0	0	0	0	70.02	0	0	12.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	5	13	43	6	32	0	0	0	0	0	0	0	70.02	0	0	12.6
2015	7	5	13	53	6	31	0	0	0	0	0	0	0	70.05	0	0	12.6
2015	7	5	14	3	6	32	0	0	0	0	0	0	0	70.14	0	0	12.8
2015	7	5	14	13	6	33	0	0	0	0	0	0	0	70.16	0	0	12.4
2015	7	5	14	23	6	32	0	0	0	0	0	0	0	70.2	0	0	12.6
2015	7	5	14	33	6	32	0	0	0	0	0	0	0	70.18	0	0	12.4
2015	7	5	14	43	6	32	0	0	0	0	0	0	0	70.2	0	0	12.4
2015	7	5	14	53	6	32	0	0	0	0	0	0	0	70.21	0	0	12.4
2015	7	5	15	3	6	32	0	0	0	0	0	0	0	70.2	0	0	12.4
2015	7	5	15	13	6	32	0	0	0	0	0	0	0	70.2	0	0	12.2
2015	7	5	15	23	6	32	0	0	0	0	0	0	0	70.18	0	0	12.2
2015	7	5	15	33	6	32	0	0	0	0	0	0	0	70.2	0	0	12.2
2015	7	5	15	43	6	32	0	0	0	0	0	0	0	70.2	0	0	12.2
2015	7	5	15	53	6	32	0	0	0	0	0	0	0	70.23	0	0	12.4
2015	7	5	16	3	6	32	0	0	0	0	0	0	0	70.23	0	0	12.4
2015	7	5	16	13	6	32	0	0	0	0	0	0	0	70.25	0	0	12.2
2015	7	5	16	23	6	32	0	0	0	0	0	0	0	70.27	0	0	12.4
2015	7	5	16	33	6	31	0	0	0	0	0	0	0	70.27	0	0	12.2
2015	7	5	16	43	6	32	0	0	0	0	0	0	0	70.25	0	0	12.2
2015	7	5	16	53	6	33	0	0	0	0	0	0	0	70.23	0	0	12.2
2015	7	5	17	3	6	32	0	0	0	0	0	0	0	70.23	0	0	12.2
2015	7	5	17	13	6	32	0	0	0	0	0	0	0	70.23	0	0	12.2
2015	7	5	17	23	6	32	0	0	0	0	0	0	0	70.23	0	0	12.2
2015	7	5	17	33	6	33	0	0	0	0	0	0	0	70.25	0	0	12.2
2015	7	5	17	43	6	32	0	0	0	0	0	0	0	70.27	0	0	12.2
2015	7	5	17	53	6	32	0	0	0	0	0	0	0	70.27	0	0	12.2
2015	7	5	18	3	6	32	0	0	0	0	0	0	0	70.27	0	0	12.2
2015	7	5	18	13	6	32	0	0	0	0	0	0	0	70.23	0	0	12.2
2015	7	5	18	23	6	33	0	0	0	0	0	0	0	70.23	0	0	12.2
2015	7	5	18	33	6	32	0	0	0	0	0	0	0	70.25	0	0	12.2
2015	7	5	18	43	6	32	0	0	0	0	0	0	0	70.21	0	0	12
2015	7	5	18	53	6	32	0	0	0	0	0	0	0	70.2	0	0	12
2015	7	5	19	3	6	31	0	0	0	0	0	0	0	70.16	0	0	12
2015	7	5	19	13	6	31	0	0	0	0	0	0	0	70.16	0	0	12
2015	7	5	19	23	6	32	0	0	0	0	0	0	0	70.14	0	0	12
2015	7	5	19	33	6	32	0	0	0	0	0	0	0	70.12	0	0	10.6
2015	7	5	19	43	6	33	0	0	0	0	0	0	0	70.12	0	0	10.4
2015	7	5	19	53	6	32	0	0	0	0	0	0	0	70.11	0	0	10.2
2015	7	5	20	3	6	32	0	0	0	0	0	0	0	70.11	0	0	10.2
2015	7	5	20	13	6	32	0	0	0	0	0	0	0	70.09	0	0	10
2015	7	5	20	23	6	32	0	0	0	0	0	0	0	70.09	0	0	10.2
2015	7	5	20	33	6	32	0	0	0	0	0	0	0	70.07	0	0	11.6
2015	7	5	20	43	6	32	0	0	0	0	0	0	0	70.05	0	0	12
2015	7	5	20	53	6	31	0	0	0	0	0	0	0	70.03	0	0	12
2015	7	5	21	3	6	31	0	0	0	0	0	0	0	70.03	0	0	12
2015	7	5	21	13	6	33	0	0	0	0	0	0	0	70	0	0	11.8
2015	7	5	21	23	6	32	0	0	0	0	0	0	0	69.98	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	5	21	33	6	32	0	0	0	0	0	0	0	69.96	0	0	12
2015	7	5	21	43	6	31	0	0	0	0	0	0	0	69.94	0	0	12
2015	7	5	21	53	6	32	0	0	0	0	0	0	0	69.93	0	0	12
2015	7	5	22	3	6	32	0	0	0	0	0	0	0	69.93	0	0	12
2015	7	5	22	13	6	32	0	0	0	0	0	0	0	69.91	0	0	12
2015	7	5	22	23	6	32	0	0	0	0	0	0	0	69.87	0	0	12
2015	7	5	22	33	6	32	0	0	0	0	0	0	0	69.85	0	0	11.8
2015	7	5	22	43	6	32	0	0	0	0	0	0	0	69.84	0	0	11.8
2015	7	5	22	53	6	32	0	0	0	0	0	0	0	69.8	0	0	11.8
2015	7	5	23	3	6	32	0	0	0	0	0	0	0	69.78	0	0	11.8
2015	7	5	23	13	6	32	0	0	0	0	0	0	0	69.76	0	0	11.8
2015	7	5	23	23	6	32	0	0	0	0	0	0	0	69.75	0	0	11.8
2015	7	5	23	33	6	31	0	0	0	0	0	0	0	69.73	0	0	11.8
2015	7	5	23	43	6	33	0	0	0	0	0	0	0	69.71	0	0	11.8
2015	7	5	23	53	6	32	0	0	0	0	0	0	0	69.69	0	0	11.8
2015	7	6	0	3	6	32	0	0	0	0	0	0	0	69.67	0	0	11.8
2015	7	6	0	13	6	32	0	0	0	0	0	0	0	69.66	0	0	11.8
2015	7	6	0	23	6	32	0	0	0	0	0	0	0	69.64	0	0	11.8
2015	7	6	0	33	6	32	0	0	0	0	0	0	0	69.6	0	0	10.4
2015	7	6	0	43	6	32	0	0	0	0	0	0	0	69.58	0	0	10.4
2015	7	6	0	53	6	32	0	0	0	0	0	0	0	69.55	0	0	10.2
2015	7	6	1	3	6	32	0	0	0	0	0	0	0	69.53	0	0	10.2
2015	7	6	1	13	6	32	0	0	0	0	0	0	0	69.49	0	0	10.2
2015	7	6	1	23	6	32	0	0	0	0	0	0	0	69.48	0	0	10.2
2015	7	6	1	33	6	32	0	0	0	0	0	0	0	69.44	0	0	11.4
2015	7	6	1	43	6	32	0	0	0	0	0	0	0	69.4	0	0	10.8
2015	7	6	1	53	6	33	0	0	0	0	0	0	0	69.39	0	0	10.6
2015	7	6	2	3	6	31	0	0	0	0	0	0	0	69.35	0	0	10.4
2015	7	6	2	13	6	32	0	0	0	0	0	0	0	69.31	0	0	10
2015	7	6	2	23	6	32	0	0	0	0	0	0	0	69.28	0	0	10
2015	7	6	2	33	6	32	0	0	0	0	0	0	0	69.24	0	0	11.8
2015	7	6	2	43	6	33	0	0	0	0	0	0	0	69.19	0	0	11.8
2015	7	6	2	53	6	32	0	0	0	0	0	0	0	69.15	0	0	11.8
2015	7	6	3	3	6	33	0	0	0	0	0	0	0	69.1	0	0	11.8
2015	7	6	3	13	6	32	0	0	0	0	0	0	0	69.04	0	0	11.8
2015	7	6	3	23	6	33	0	0	0	0	0	0	0	69.01	0	0	11.8
2015	7	6	3	33	6	33	0	0	0	0	0	0	0	68.95	0	0	11.8
2015	7	6	3	43	6	32	0	0	0	0	0	0	0	68.9	0	0	11.8
2015	7	6	3	53	6	32	0	0	0	0	0	0	0	68.86	0	0	11.8
2015	7	6	4	3	6	32	0	0	0	0	0	0	0	68.81	0	0	11.8
2015	7	6	4	13	6	32	0	0	0	0	0	0	0	68.76	0	0	11.6
2015	7	6	4	23	6	32	0	0	0	0	0	0	0	68.72	0	0	11.6
2015	7	6	4	33	6	32	0	0	0	0	0	0	0	68.63	0	0	11.8
2015	7	6	4	43	6	32	0	0	0	0	0	0	0	68.59	0	0	11.8
2015	7	6	4	53	6	33	0	0	0	0	0	0	0	68.54	0	0	11.8
2015	7	6	5	3	6	31	0	0	0	0	0	0	0	68.49	0	0	11.8
2015	7	6	5	13	6	32	0	0	0	0	0	0	0	68.43	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	6	5	23	6	32		0	0	0	0	0	0	68.36	0	0	11.8
2015	7	6	5	33	6	32		0	0	0	0	0	0	68.31	0	0	11.8
2015	7	6	5	43	6	32		0	0	0	0	0	0	68.25	0	0	11.8
2015	7	6	5	53	6	33		0	0	0	0	0	0	68.2	0	0	11.8
2015	7	6	6	3	6	32		0	0	0	0	0	0	68.14	0	0	11.8
2015	7	6	6	13	6	32		0	0	0	0	0	0	68.09	0	0	11.8
2015	7	6	6	23	6	32		0	0	0	0	0	0	68.04	0	0	11.8
2015	7	6	6	33	6	32		0	0	0	0	0	0	67.98	0	0	11.8
2015	7	6	6	43	6	32		0	0	0	0	0	0	67.93	0	0	11.8
2015	7	6	6	53	6	32		0	0	0	0	0	0	67.89	0	0	11.8
2015	7	6	7	3	6	32		0	0	0	0	0	0	67.84	0	0	11.8
2015	7	6	7	13	6	33		0	0	0	0	0	0	67.8	0	0	12
2015	7	6	7	23	6	33		0	0	0	0	0	0	67.8	0	0	12
2015	7	6	7	33	6	33		0	0	0	0	0	0	67.77	0	0	12.2
2015	7	6	7	43	6	32		0	0	0	0	0	0	67.77	0	0	12.2
2015	7	6	7	53	6	32		0	0	0	0	0	0	67.77	0	0	12.4
2015	7	6	8	3	6	33		0	0	0	0	0	0	67.77	0	0	12.4
2015	7	6	8	13	6	32		0	0	0	0	0	0	67.77	0	0	12.4
2015	7	6	8	23	6	32		0	0	0	0	0	0	67.77	0	0	12.4
2015	7	6	8	33	6	32		0	0	0	0	0	0	67.77	0	0	13
2015	7	6	8	43	6	31		0	0	0	0	0	0	67.78	0	0	13.2
2015	7	6	8	53	6	32		0	0	0	0	0	0	67.82	0	0	14
2015	7	6	9	3	6	32		0	0	0	0	0	0	67.84	0	0	14.2
2015	7	6	9	13	6	32		0	0	0	0	0	0	67.86	0	0	13.8
2015	7	6	9	23	6	32		0	0	0	0	0	0	67.87	0	0	14.2
2015	7	6	9	33	6	32		0	0	0	0	0	0	67.93	0	0	13.4
2015	7	6	9	43	6	32		0	0	0	0	0	0	67.96	0	0	13.4
2015	7	6	9	53	6	33		0	0	0	0	0	0	68	0	0	13.4
2015	7	6	10	3	6	33		0	0	0	0	0	0	68.05	0	0	13.2
2015	7	6	10	13	6	33		0	0	0	0	0	0	68.13	0	0	13.2
2015	7	6	10	23	6	32		0	0	0	0	0	0	68.14	0	0	13.2
2015	7	6	10	33	6	32		0	0	0	0	0	0	68.22	0	0	13.2
2015	7	6	10	43	6	32		0	0	0	0	0	0	68.27	0	0	13
2015	7	6	10	53	6	33		0	0	0	0	0	0	68.32	0	0	13.2
2015	7	6	11	3	6	32		0	0	0	0	0	0	68.38	0	0	13.2
2015	7	6	11	13	6	32		0	0	0	0	0	0	68.43	0	0	13
2015	7	6	11	23	6	32		0	0	0	0	0	0	68.5	0	0	13
2015	7	6	11	33	6	33		0	0	0	0	0	0	68.54	0	0	13.8
2015	7	6	11	43	6	33		0	0	0	0	0	0	68.61	0	0	13.6
2015	7	6	11	53	6	32		0	0	0	0	0	0	68.68	0	0	14.2
2015	7	6	12	3	6	32		0	0	0	0	0	0	68.74	0	0	14.2
2015	7	6	12	13	6	33		0	0	0	0	0	0	68.81	0	0	14.2
2015	7	6	12	23	6	32		0	0	0	0	0	0	68.92	0	0	14.2
2015	7	6	12	33	6	32		0	0	0	0	0	0	68.94	0	0	14
2015	7	6	12	43	6	33		0	0	0	0	0	0	68.94	0	0	14.2
2015	7	6	12	53	6	32		0	0	0	0	0	0	69.04	0	0	14.2
2015	7	6	13	3	6	32		0	0	0	0	0	0	69.08	0	0	14.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	6	13	13	6	33	0	0	0	0	0	0	0	68.95	0	0	13
2015	7	6	13	23	6	32	0	0	0	0	0	0	0	69.22	0	0	14
2015	7	6	13	33	6	32	0	0	0	0	0	0	0	69.13	0	0	13.4
2015	7	6	13	43	6	32	0	0	0	0	0	0	0	69.33	0	0	13.8
2015	7	6	13	53	6	32	0	0	0	0	0	0	0	69.39	0	0	13.8
2015	7	6	14	3	6	31	0	0	0	0	0	0	0	69.44	0	0	13.6
2015	7	6	14	13	6	33	0	0	0	0	0	0	0	69.51	0	0	14
2015	7	6	14	23	6	32	0	0	0	0	0	0	0	69.58	0	0	13.8
2015	7	6	14	33	6	33	0	0	0	0	0	0	0	69.64	0	0	13.6
2015	7	6	14	43	6	33	0	0	0	0	0	0	0	69.46	0	0	13
2015	7	6	14	53	6	31	0	0	0	0	0	0	0	69.6	0	0	14
2015	7	6	15	3	6	32	0	0	0	0	0	0	0	69.69	0	0	13.8
2015	7	6	15	13	6	32	0	0	0	0	0	0	0	69.55	0	0	12.8
2015	7	6	15	23	6	32	0	0	0	0	0	0	0	69.49	0	0	12.4
2015	7	6	15	33	6	32	0	0	0	0	0	0	0	69.46	0	0	12.2
2015	7	6	15	43	6	32	0	0	0	0	0	0	0	69.44	0	0	12.2
2015	7	6	15	53	6	32	0	0	0	0	0	0	0	69.46	0	0	12.2
2015	7	6	16	3	6	33	0	0	0	0	0	0	0	69.46	0	0	12.2
2015	7	6	16	13	6	32	0	0	0	0	0	0	0	69.48	0	0	12.2
2015	7	6	16	23	6	33	0	0	0	0	0	0	0	69.48	0	0	12
2015	7	6	16	33	6	32	0	0	0	0	0	0	0	69.49	0	0	12
2015	7	6	16	43	6	32	0	0	0	0	0	0	0	69.51	0	0	12
2015	7	6	16	53	6	32	0	0	0	0	0	0	0	69.53	0	0	12
2015	7	6	17	3	6	32	0	0	0	0	0	0	0	69.53	0	0	12
2015	7	6	17	13	6	33	0	0	0	0	0	0	0	69.53	0	0	12
2015	7	6	17	23	6	33	0	0	0	0	0	0	0	69.55	0	0	12
2015	7	6	17	33	6	32	0	0	0	0	0	0	0	69.55	0	0	12
2015	7	6	17	43	6	32	0	0	0	0	0	0	0	69.55	0	0	12
2015	7	6	17	53	6	32	0	0	0	0	0	0	0	69.55	0	0	12
2015	7	6	18	3	6	32	0	0	0	0	0	0	0	69.55	0	0	12
2015	7	6	18	13	6	32	0	0	0	0	0	0	0	69.55	0	0	12
2015	7	6	18	23	6	33	0	0	0	0	0	0	0	69.55	0	0	12
2015	7	6	18	33	6	32	0	0	0	0	0	0	0	69.55	0	0	12
2015	7	6	18	43	6	32	0	0	0	0	0	0	0	69.55	0	0	12
2015	7	6	18	53	6	32	0	0	0	0	0	0	0	69.55	0	0	12
2015	7	6	19	3	6	31	0	0	0	0	0	0	0	69.53	0	0	12
2015	7	6	19	13	6	32	0	0	0	0	0	0	0	69.53	0	0	12
2015	7	6	19	23	6	32	0	0	0	0	0	0	0	69.53	0	0	12
2015	7	6	19	33	6	32	0	0	0	0	0	0	0	69.51	0	0	11.6
2015	7	6	19	43	6	32	0	0	0	0	0	0	0	69.51	0	0	11.4
2015	7	6	19	53	6	32	0	0	0	0	0	0	0	69.49	0	0	11.4
2015	7	6	20	3	6	32	0	0	0	0	0	0	0	69.48	0	0	11.4
2015	7	6	20	13	6	33	0	0	0	0	0	0	0	69.48	0	0	11.4
2015	7	6	20	23	6	32	0	0	0	0	0	0	0	69.46	0	0	11.4
2015	7	6	20	33	6	32	0	0	0	0	0	0	0	69.44	0	0	11.8
2015	7	6	20	43	6	32	0	0	0	0	0	0	0	69.44	0	0	11.8
2015	7	6	20	53	6	32	0	0	0	0	0	0	0	69.42	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	6	21	3	6	32	0	0	0	0	0	0	0	69.4	0	0	11.8
2015	7	6	21	13	6	32	0	0	0	0	0	0	0	69.4	0	0	11.8
2015	7	6	21	23	6	32	0	0	0	0	0	0	0	69.39	0	0	11.8
2015	7	6	21	33	6	32	0	0	0	0	0	0	0	69.39	0	0	11.8
2015	7	6	21	43	6	33	0	0	0	0	0	0	0	69.37	0	0	11.8
2015	7	6	21	53	6	32	0	0	0	0	0	0	0	69.37	0	0	11.8
2015	7	6	22	3	6	33	0	0	0	0	0	0	0	69.37	0	0	11.8
2015	7	6	22	13	6	32	0	0	0	0	0	0	0	69.37	0	0	11.8
2015	7	6	22	23	6	32	0	0	0	0	0	0	0	69.37	0	0	11.8
2015	7	6	22	33	6	32	0	0	0	0	0	0	0	69.37	0	0	11.8
2015	7	6	22	43	6	32	0	0	0	0	0	0	0	69.35	0	0	11.8
2015	7	6	22	53	6	31	0	0	0	0	0	0	0	69.35	0	0	11.8
2015	7	6	23	3	6	32	0	0	0	0	0	0	0	69.35	0	0	11.8
2015	7	6	23	13	6	33	0	0	0	0	0	0	0	69.33	0	0	11.8
2015	7	6	23	23	6	32	0	0	0	0	0	0	0	69.33	0	0	11.8
2015	7	6	23	33	6	32	0	0	0	0	0	0	0	69.33	0	0	11.8
2015	7	6	23	43	6	32	0	0	0	0	0	0	0	69.33	0	0	11.8
2015	7	6	23	53	6	32	0	0	0	0	0	0	0	69.33	0	0	11.8
2015	7	7	0	3	6	32	0	0	0	0	0	0	0	69.35	0	0	11.8
2015	7	7	0	13	6	32	0	0	0	0	0	0	0	69.33	0	0	11.8
2015	7	7	0	23	6	32	0	0	0	0	0	0	0	69.33	0	0	11.8
2015	7	7	0	33	6	32	0	0	0	0	0	0	0	69.33	0	0	11.8
2015	7	7	0	43	6	33	0	0	0	0	0	0	0	69.33	0	0	11.8
2015	7	7	0	53	6	32	0	0	0	0	0	0	0	69.33	0	0	11.8
2015	7	7	1	3	6	32	0	0	0	0	0	0	0	69.33	0	0	11.8
2015	7	7	1	13	6	33	0	0	0	0	0	0	0	69.33	0	0	11.8
2015	7	7	1	23	6	32	0	0	0	0	0	0	0	69.31	0	0	11.8
2015	7	7	1	33	6	32	0	0	0	0	0	0	0	69.31	0	0	11.8
2015	7	7	1	43	6	32	0	0	0	0	0	0	0	69.31	0	0	11.8
2015	7	7	1	53	6	32	0	0	0	0	0	0	0	69.3	0	0	11.8
2015	7	7	2	3	6	32	0	0	0	0	0	0	0	69.3	0	0	11.8
2015	7	7	2	13	6	32	0	0	0	0	0	0	0	69.28	0	0	11.8
2015	7	7	2	23	6	33	0	0	0	0	0	0	0	69.26	0	0	11.8
2015	7	7	2	33	6	32	0	0	0	0	0	0	0	69.24	0	0	11.8
2015	7	7	2	43	6	32	0	0	0	0	0	0	0	69.24	0	0	11.8
2015	7	7	2	53	6	32	0	0	0	0	0	0	0	69.21	0	0	11.8
2015	7	7	3	3	6	32	0	0	0	0	0	0	0	69.19	0	0	11.8
2015	7	7	3	13	6	32	0	0	0	0	0	0	0	69.15	0	0	11.8
2015	7	7	3	23	6	32	0	0	0	0	0	0	0	69.13	0	0	11.8
2015	7	7	3	33	6	32	0	0	0	0	0	0	0	69.12	0	0	11.8
2015	7	7	3	43	6	32	0	0	0	0	0	0	0	69.08	0	0	11.8
2015	7	7	3	53	6	32	0	0	0	0	0	0	0	69.04	0	0	11.6
2015	7	7	4	3	6	32	0	0	0	0	0	0	0	69.01	0	0	11.6
2015	7	7	4	13	6	32	0	0	0	0	0	0	0	68.95	0	0	11.6
2015	7	7	4	23	6	31	0	0	0	0	0	0	0	68.92	0	0	11.6
2015	7	7	4	33	6	33	0	0	0	0	0	0	0	68.9	0	0	11.8
2015	7	7	4	43	6	32	0	0	0	0	0	0	0	68.85	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	7	4	53	6	32		0	0	0	0	0	0	68.81	0	0	11.8
2015	7	7	5	3	6	33		0	0	0	0	0	0	68.76	0	0	11.6
2015	7	7	5	13	6	32		0	0	0	0	0	0	68.72	0	0	11.6
2015	7	7	5	23	6	32		0	0	0	0	0	0	68.68	0	0	11.6
2015	7	7	5	33	6	32		0	0	0	0	0	0	68.63	0	0	11.8
2015	7	7	5	43	6	33		0	0	0	0	0	0	68.61	0	0	11.8
2015	7	7	5	53	6	32		0	0	0	0	0	0	68.56	0	0	11.8
2015	7	7	6	3	6	33		0	0	0	0	0	0	68.52	0	0	11.8
2015	7	7	6	13	6	32		0	0	0	0	0	0	68.47	0	0	11.8
2015	7	7	6	23	6	33		0	0	0	0	0	0	68.43	0	0	11.8
2015	7	7	6	33	6	33		0	0	0	0	0	0	68.4	0	0	11.8
2015	7	7	6	43	6	32		0	0	0	0	0	0	68.34	0	0	11.8
2015	7	7	6	53	6	32		0	0	0	0	0	0	68.31	0	0	11.8
2015	7	7	7	3	6	33		0	0	0	0	0	0	68.29	0	0	11.8
2015	7	7	7	13	6	32		0	0	0	0	0	0	68.25	0	0	12
2015	7	7	7	23	6	32		0	0	0	0	0	0	68.25	0	0	12
2015	7	7	7	33	6	32		0	0	0	0	0	0	68.25	0	0	12.2
2015	7	7	7	43	6	32		0	0	0	0	0	0	68.23	0	0	12.2
2015	7	7	7	53	6	33		0	0	0	0	0	0	68.25	0	0	12.4
2015	7	7	8	3	6	33		0	0	0	0	0	0	68.23	0	0	12.4
2015	7	7	8	13	6	32		0	0	0	0	0	0	68.23	0	0	12.6
2015	7	7	8	23	6	32		0	0	0	0	0	0	68.25	0	0	12.8
2015	7	7	8	33	6	32		0	0	0	0	0	0	68.27	0	0	12.8
2015	7	7	8	43	6	32		0	0	0	0	0	0	68.29	0	0	13
2015	7	7	8	53	6	32		0	0	0	0	0	0	68.25	0	0	12.8
2015	7	7	9	3	6	32		0	0	0	0	0	0	68.32	0	0	13.4
2015	7	7	9	13	6	32		0	0	0	0	0	0	68.34	0	0	13.6
2015	7	7	9	23	6	33		0	0	0	0	0	0	68.4	0	0	13.4
2015	7	7	9	33	6	32		0	0	0	0	0	0	68.43	0	0	13.2
2015	7	7	9	43	6	32		0	0	0	0	0	0	68.47	0	0	13.2
2015	7	7	9	53	6	32		0	0	0	0	0	0	68.5	0	0	13.2
2015	7	7	10	3	6	32		0	0	0	0	0	0	68.56	0	0	13.2
2015	7	7	10	13	6	32		0	0	0	0	0	0	68.59	0	0	13.4
2015	7	7	10	23	6	32		0	0	0	0	0	0	68.65	0	0	13
2015	7	7	10	33	6	31		0	0	0	0	0	0	68.72	0	0	13.2
2015	7	7	10	43	6	32		0	0	0	0	0	0	68.76	0	0	13
2015	7	7	10	53	6	32		0	0	0	0	0	0	68.83	0	0	13.2
2015	7	7	11	3	6	33		0	0	0	0	0	0	68.86	0	0	13
2015	7	7	11	13	6	33		0	0	0	0	0	0	68.92	0	0	13
2015	7	7	11	23	6	32		0	0	0	0	0	0	68.99	0	0	13
2015	7	7	11	33	6	32		0	0	0	0	0	0	69.03	0	0	14
2015	7	7	11	43	6	32		0	0	0	0	0	0	69.08	0	0	13.4
2015	7	7	11	53	6	31		0	0	0	0	0	0	69.12	0	0	13.4
2015	7	7	12	3	6	32		0	0	0	0	0	0	69.17	0	0	13.4
2015	7	7	12	13	6	32		0	0	0	0	0	0	69.21	0	0	13.4
2015	7	7	12	23	6	32		0	0	0	0	0	0	69.28	0	0	13.4
2015	7	7	12	33	6	32		0	0	0	0	0	0	69.33	0	0	13.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	7	12	43	6	32		0	0	0	0	0	0	69.4	0	0	13.2
2015	7	7	12	53	6	31		0	0	0	0	0	0	69.44	0	0	13.2
2015	7	7	13	3	6	32		0	0	0	0	0	0	69.48	0	0	13.2
2015	7	7	13	13	6	33		0	0	0	0	0	0	69.55	0	0	13
2015	7	7	13	23	6	32		0	0	0	0	0	0	69.58	0	0	13.2
2015	7	7	13	33	6	32		0	0	0	0	0	0	69.64	0	0	14.2
2015	7	7	13	43	6	32		0	0	0	0	0	0	69.69	0	0	14.2
2015	7	7	13	53	6	32		0	0	0	0	0	0	69.71	0	0	14.2
2015	7	7	14	3	6	33		0	0	0	0	0	0	69.76	0	0	13.4
2015	7	7	14	13	6	31		0	0	0	0	0	0	69.82	0	0	13.6
2015	7	7	14	23	6	33		0	0	0	0	0	0	69.84	0	0	13.4
2015	7	7	14	33	6	32		0	0	0	0	0	0	69.87	0	0	14
2015	7	7	14	43	6	32		0	0	0	0	0	0	69.91	0	0	14
2015	7	7	14	53	6	33		0	0	0	0	0	0	69.94	0	0	14
2015	7	7	15	3	6	32		0	0	0	0	0	0	69.98	0	0	14
2015	7	7	15	13	6	32		0	0	0	0	0	0	70	0	0	13.8
2015	7	7	15	23	6	32		0	0	0	0	0	0	70.02	0	0	13.6
2015	7	7	15	33	6	32		0	0	0	0	0	0	70.02	0	0	13.4
2015	7	7	15	43	6	32		0	0	0	0	0	0	70.03	0	0	13.6
2015	7	7	15	53	6	31		0	0	0	0	0	0	70.03	0	0	13.4
2015	7	7	16	3	6	32		0	0	0	0	0	0	70.05	0	0	13.4
2015	7	7	16	13	6	33		0	0	0	0	0	0	70.03	0	0	13.4
2015	7	7	16	23	6	32		0	0	0	0	0	0	70.03	0	0	13.4
2015	7	7	16	33	6	32		0	0	0	0	0	0	70.03	0	0	13.2
2015	7	7	16	43	6	32		0	0	0	0	0	0	70.02	0	0	13.2
2015	7	7	16	53	6	32		0	0	0	0	0	0	70.02	0	0	13
2015	7	7	17	3	6	33		0	0	0	0	0	0	70	0	0	12.8
2015	7	7	17	13	6	31		0	0	0	0	0	0	69.98	0	0	12.6
2015	7	7	17	23	6	31		0	0	0	0	0	0	69.94	0	0	12.6
2015	7	7	17	33	6	32		0	0	0	0	0	0	69.94	0	0	12.2
2015	7	7	17	43	6	33		0	0	0	0	0	0	69.91	0	0	12.2
2015	7	7	17	53	6	32		0	0	0	0	0	0	69.87	0	0	12.2
2015	7	7	18	3	6	32		0	0	0	0	0	0	69.85	0	0	12.2
2015	7	7	18	13	6	32		0	0	0	0	0	0	69.84	0	0	12
2015	7	7	18	23	6	32		0	0	0	0	0	0	69.82	0	0	12
2015	7	7	18	33	6	32		0	0	0	0	0	0	69.8	0	0	12
2015	7	7	18	43	6	32		0	0	0	0	0	0	69.8	0	0	12
2015	7	7	18	53	6	33		0	0	0	0	0	0	69.76	0	0	12
2015	7	7	19	3	6	31		0	0	0	0	0	0	69.75	0	0	12
2015	7	7	19	13	6	33		0	0	0	0	0	0	69.73	0	0	12
2015	7	7	19	23	6	31		0	0	0	0	0	0	69.71	0	0	12
2015	7	7	19	33	6	31		0	0	0	0	0	0	69.69	0	0	12
2015	7	7	19	43	6	32		0	0	0	0	0	0	69.67	0	0	12
2015	7	7	19	53	6	32		0	0	0	0	0	0	69.66	0	0	12
2015	7	7	20	3	6	32		0	0	0	0	0	0	69.64	0	0	12
2015	7	7	20	13	6	32		0	0	0	0	0	0	69.64	0	0	11.8
2015	7	7	20	23	6	32		0	0	0	0	0	0	69.62	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	7	20	33	6	32		0	0	0	0	0	0	69.62	0	0	11.8
2015	7	7	20	43	6	32		0	0	0	0	0	0	69.6	0	0	11.8
2015	7	7	20	53	6	32		0	0	0	0	0	0	69.58	0	0	11.8
2015	7	7	21	3	6	32		0	0	0	0	0	0	69.58	0	0	11.8
2015	7	7	21	13	6	32		0	0	0	0	0	0	69.57	0	0	11.8
2015	7	7	21	23	6	32		0	0	0	0	0	0	69.55	0	0	11.8
2015	7	7	21	33	6	32		0	0	0	0	0	0	69.55	0	0	11.8
2015	7	7	21	43	6	32		0	0	0	0	0	0	69.53	0	0	11.8
2015	7	7	21	53	6	32		0	0	0	0	0	0	69.51	0	0	11.8
2015	7	7	22	3	6	32		0	0	0	0	0	0	69.49	0	0	11.8
2015	7	7	22	13	6	33		0	0	0	0	0	0	69.48	0	0	11.8
2015	7	7	22	23	6	33		0	0	0	0	0	0	69.46	0	0	11.8
2015	7	7	22	33	6	32		0	0	0	0	0	0	69.42	0	0	11.8
2015	7	7	22	43	6	33		0	0	0	0	0	0	69.4	0	0	11.8
2015	7	7	22	53	6	32		0	0	0	0	0	0	69.37	0	0	11.8
2015	7	7	23	3	6	32		0	0	0	0	0	0	69.33	0	0	11.8
2015	7	7	23	13	6	32		0	0	0	0	0	0	69.31	0	0	11.8
2015	7	7	23	23	6	32		0	0	0	0	0	0	69.28	0	0	11.8
2015	7	7	23	33	6	32		0	0	0	0	0	0	69.26	0	0	11.8
2015	7	7	23	43	6	31		0	0	0	0	0	0	69.22	0	0	11.8
2015	7	7	23	53	6	32		0	0	0	0	0	0	69.21	0	0	11.8
2015	7	8	0	3	6	32		0	0	0	0	0	0	69.19	0	0	11.8
2015	7	8	0	13	6	32		0	0	0	0	0	0	69.17	0	0	11.8
2015	7	8	0	23	6	32		0	0	0	0	0	0	69.15	0	0	11.8
2015	7	8	0	33	6	33		0	0	0	0	0	0	69.13	0	0	11.8
2015	7	8	0	43	6	32		0	0	0	0	0	0	69.12	0	0	11.8
2015	7	8	0	53	6	32		0	0	0	0	0	0	69.1	0	0	11.8
2015	7	8	1	3	6	32		0	0	0	0	0	0	69.1	0	0	11.8
2015	7	8	1	13	6	32		0	0	0	0	0	0	69.08	0	0	11.8
2015	7	8	1	23	6	32		0	0	0	0	0	0	69.06	0	0	11.8
2015	7	8	1	33	6	33		0	0	0	0	0	0	69.04	0	0	11.8
2015	7	8	1	43	6	32		0	0	0	0	0	0	69.03	0	0	11.8
2015	7	8	1	53	6	32		0	0	0	0	0	0	69.01	0	0	11.8
2015	7	8	2	3	6	32		0	0	0	0	0	0	69.01	0	0	11.8
2015	7	8	2	13	6	32		0	0	0	0	0	0	68.97	0	0	11.8
2015	7	8	2	23	6	32		0	0	0	0	0	0	68.97	0	0	11.8
2015	7	8	2	33	6	32		0	0	0	0	0	0	68.95	0	0	11.8
2015	7	8	2	43	6	31		0	0	0	0	0	0	68.94	0	0	11.8
2015	7	8	2	53	6	32		0	0	0	0	0	0	68.9	0	0	11.8
2015	7	8	3	3	6	32		0	0	0	0	0	0	68.9	0	0	11.8
2015	7	8	3	13	6	32		0	0	0	0	0	0	68.86	0	0	11.8
2015	7	8	3	23	6	32		0	0	0	0	0	0	68.85	0	0	11.8
2015	7	8	3	33	6	32		0	0	0	0	0	0	68.83	0	0	11.8
2015	7	8	3	43	6	32		0	0	0	0	0	0	68.81	0	0	11.8
2015	7	8	3	53	6	33		0	0	0	0	0	0	68.77	0	0	11.8
2015	7	8	4	3	6	32		0	0	0	0	0	0	68.74	0	0	11.8
2015	7	8	4	13	6	32		0	0	0	0	0	0	68.72	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	8	4	23	6	32		0	0	0	0	0	0	68.68	0	0	11.8
2015	7	8	4	33	6	32		0	0	0	0	0	0	68.65	0	0	11.8
2015	7	8	4	43	6	32		0	0	0	0	0	0	68.61	0	0	11.8
2015	7	8	4	53	6	33		0	0	0	0	0	0	68.58	0	0	11.8
2015	7	8	5	3	6	32		0	0	0	0	0	0	68.54	0	0	11.8
2015	7	8	5	13	6	32		0	0	0	0	0	0	68.52	0	0	11.8
2015	7	8	5	23	6	33		0	0	0	0	0	0	68.49	0	0	11.8
2015	7	8	5	33	6	32		0	0	0	0	0	0	68.45	0	0	11.8
2015	7	8	5	43	6	33		0	0	0	0	0	0	68.41	0	0	11.6
2015	7	8	5	53	6	32		0	0	0	0	0	0	68.38	0	0	11.8
2015	7	8	6	3	6	33		0	0	0	0	0	0	68.32	0	0	11.8
2015	7	8	6	13	6	32		0	0	0	0	0	0	68.29	0	0	11.8
2015	7	8	6	23	6	32		0	0	0	0	0	0	68.23	0	0	11.8
2015	7	8	6	33	6	32		0	0	0	0	0	0	68.2	0	0	11.6
2015	7	8	6	43	6	31		0	0	0	0	0	0	68.14	0	0	11.8
2015	7	8	6	53	6	32		0	0	0	0	0	0	68.11	0	0	11.8
2015	7	8	7	3	6	31		0	0	0	0	0	0	68.07	0	0	11.8
2015	7	8	7	13	6	33		0	0	0	0	0	0	68.04	0	0	12
2015	7	8	7	23	6	33		0	0	0	0	0	0	68.04	0	0	12
2015	7	8	7	33	6	33		0	0	0	0	0	0	68.02	0	0	12
2015	7	8	7	43	6	32		0	0	0	0	0	0	68	0	0	12.2
2015	7	8	7	53	6	33		0	0	0	0	0	0	67.98	0	0	12.2
2015	7	8	8	3	6	32		0	0	0	0	0	0	67.98	0	0	12.4
2015	7	8	8	13	6	32		0	0	0	0	0	0	67.98	0	0	12.4
2015	7	8	8	23	6	32		0	0	0	0	0	0	67.98	0	0	12.6
2015	7	8	8	33	6	32		0	0	0	0	0	0	67.98	0	0	12.8
2015	7	8	8	43	6	32		0	0	0	0	0	0	68	0	0	12.8
2015	7	8	8	53	6	32		0	0	0	0	0	0	68.02	0	0	12.8
2015	7	8	9	3	6	32		0	0	0	0	0	0	67.96	0	0	13
2015	7	8	9	13	6	33		0	0	0	0	0	0	67.98	0	0	13.2
2015	7	8	9	23	6	33		0	0	0	0	0	0	67.98	0	0	13.4
2015	7	8	9	33	6	32		0	0	0	0	0	0	68.09	0	0	13.2
2015	7	8	9	43	6	32		0	0	0	0	0	0	68.13	0	0	13.2
2015	7	8	9	53	6	31		0	0	0	0	0	0	68.16	0	0	13.2
2015	7	8	10	3	6	33		0	0	0	0	0	0	68.22	0	0	13.4
2015	7	8	10	13	6	32		0	0	0	0	0	0	68.25	0	0	13.4
2015	7	8	10	23	6	33		0	0	0	0	0	0	68.31	0	0	14
2015	7	8	10	33	6	32		0	0	0	0	0	0	68.36	0	0	13.6
2015	7	8	10	43	6	32		0	0	0	0	0	0	68.43	0	0	13.8
2015	7	8	10	53	6	32		0	0	0	0	0	0	68.49	0	0	14.2
2015	7	8	11	3	6	32		0	0	0	0	0	0	68.54	0	0	14.2
2015	7	8	11	13	6	33		0	0	0	0	0	0	68.58	0	0	14.2
2015	7	8	11	23	6	32		0	0	0	0	0	0	68.65	0	0	14.2
2015	7	8	11	33	6	33		0	0	0	0	0	0	68.7	0	0	14.2
2015	7	8	11	43	6	32		0	0	0	0	0	0	68.76	0	0	14.2
2015	7	8	11	53	6	33		0	0	0	0	0	0	68.81	0	0	14.2
2015	7	8	12	3	6	33		0	0	0	0	0	0	68.85	0	0	14.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	8	12	13	6	32	0	0	0	0	0	0	0	68.9	0	0	14.2
2015	7	8	12	23	6	32	0	0	0	0	0	0	0	68.95	0	0	14.2
2015	7	8	12	33	6	32	0	0	0	0	0	0	0	69.01	0	0	14.2
2015	7	8	12	43	6	32	0	0	0	0	0	0	0	69.08	0	0	14.2
2015	7	8	12	53	6	32	0	0	0	0	0	0	0	69.13	0	0	14.2
2015	7	8	13	3	6	33	0	0	0	0	0	0	0	69.21	0	0	14.2
2015	7	8	13	13	6	32	0	0	0	0	0	0	0	69.24	0	0	14.2
2015	7	8	13	23	6	31	0	0	0	0	0	0	0	69.28	0	0	14
2015	7	8	13	33	6	32	0	0	0	0	0	0	0	69.21	0	0	14.2
2015	7	8	13	43	6	32	0	0	0	0	0	0	0	69.31	0	0	13.8
2015	7	8	13	53	6	32	0	0	0	0	0	0	0	69.19	0	0	13.4
2015	7	8	14	3	6	31	0	0	0	0	0	0	0	69.33	0	0	13.8
2015	7	8	14	13	6	33	0	0	0	0	0	0	0	69.19	0	0	13.4
2015	7	8	14	23	6	32	0	0	0	0	0	0	0	69.26	0	0	14
2015	7	8	14	33	6	32	0	0	0	0	0	0	0	69.21	0	0	13.6
2015	7	8	14	43	6	32	0	0	0	0	0	0	0	69.42	0	0	14.2
2015	7	8	14	53	6	32	0	0	0	0	0	0	0	69.48	0	0	14
2015	7	8	15	3	6	32	0	0	0	0	0	0	0	69.37	0	0	13.4
2015	7	8	15	13	6	32	0	0	0	0	0	0	0	69.39	0	0	13.8
2015	7	8	15	23	6	32	0	0	0	0	0	0	0	69.31	0	0	13.2
2015	7	8	15	33	6	32	0	0	0	0	0	0	0	69.28	0	0	12.4
2015	7	8	15	43	6	32	0	0	0	0	0	0	0	69.31	0	0	13.8
2015	7	8	15	53	6	31	0	0	0	0	0	0	0	69.35	0	0	13
2015	7	8	16	3	6	33	0	0	0	0	0	0	0	69.3	0	0	12.4
2015	7	8	16	13	6	32	0	0	0	0	0	0	0	69.3	0	0	13.2
2015	7	8	16	23	6	32	0	0	0	0	0	0	0	69.4	0	0	13.6
2015	7	8	16	33	6	32	0	0	0	0	0	0	0	69.35	0	0	13
2015	7	8	16	43	6	33	0	0	0	0	0	0	0	69.4	0	0	13.2
2015	7	8	16	53	6	32	0	0	0	0	0	0	0	69.39	0	0	13.6
2015	7	8	17	3	6	31	0	0	0	0	0	0	0	69.4	0	0	13.4
2015	7	8	17	13	6	33	0	0	0	0	0	0	0	69.37	0	0	13
2015	7	8	17	23	6	32	0	0	0	0	0	0	0	69.33	0	0	12.8
2015	7	8	17	33	6	32	0	0	0	0	0	0	0	69.31	0	0	12.2
2015	7	8	17	43	6	32	0	0	0	0	0	0	0	69.28	0	0	12.2
2015	7	8	17	53	6	32	0	0	0	0	0	0	0	69.24	0	0	12.2
2015	7	8	18	3	6	32	0	0	0	0	0	0	0	69.22	0	0	12.2
2015	7	8	18	13	6	32	0	0	0	0	0	0	0	69.21	0	0	12
2015	7	8	18	23	6	32	0	0	0	0	0	0	0	69.21	0	0	12
2015	7	8	18	33	6	33	0	0	0	0	0	0	0	69.19	0	0	12
2015	7	8	18	43	6	32	0	0	0	0	0	0	0	69.17	0	0	12
2015	7	8	18	53	6	32	0	0	0	0	0	0	0	69.13	0	0	12
2015	7	8	19	3	6	32	0	0	0	0	0	0	0	69.13	0	0	11.4
2015	7	8	19	13	6	32	0	0	0	0	0	0	0	69.12	0	0	11
2015	7	8	19	23	6	33	0	0	0	0	0	0	0	69.1	0	0	11
2015	7	8	19	33	6	32	0	0	0	0	0	0	0	69.1	0	0	12
2015	7	8	19	43	6	32	0	0	0	0	0	0	0	69.08	0	0	12
2015	7	8	19	53	6	32	0	0	0	0	0	0	0	69.06	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	8	20	3	6	31	0	0	0	0	0	0	0	69.04	0	0	11.8
2015	7	8	20	13	6	32	0	0	0	0	0	0	0	69.01	0	0	11.8
2015	7	8	20	23	6	32	0	0	0	0	0	0	0	68.99	0	0	11.8
2015	7	8	20	33	6	33	0	0	0	0	0	0	0	68.97	0	0	12
2015	7	8	20	43	6	33	0	0	0	0	0	0	0	68.95	0	0	12
2015	7	8	20	53	6	32	0	0	0	0	0	0	0	68.94	0	0	12
2015	7	8	21	3	6	32	0	0	0	0	0	0	0	68.9	0	0	11.8
2015	7	8	21	13	6	32	0	0	0	0	0	0	0	68.9	0	0	11.8
2015	7	8	21	23	6	32	0	0	0	0	0	0	0	68.86	0	0	11.8
2015	7	8	21	33	6	32	0	0	0	0	0	0	0	68.86	0	0	11.8
2015	7	8	21	43	6	33	0	0	0	0	0	0	0	68.86	0	0	11.8
2015	7	8	21	53	6	32	0	0	0	0	0	0	0	68.83	0	0	11.8
2015	7	8	22	3	6	33	0	0	0	0	0	0	0	68.81	0	0	11.8
2015	7	8	22	13	6	32	0	0	0	0	0	0	0	68.79	0	0	11.8
2015	7	8	22	23	6	32	0	0	0	0	0	0	0	68.76	0	0	11.8
2015	7	8	22	33	6	33	0	0	0	0	0	0	0	68.74	0	0	11.8
2015	7	8	22	43	6	32	0	0	0	0	0	0	0	68.7	0	0	11.8
2015	7	8	22	53	6	33	0	0	0	0	0	0	0	68.67	0	0	11.8
2015	7	8	23	3	6	32	0	0	0	0	0	0	0	68.65	0	0	11.8
2015	7	8	23	13	6	32	0	0	0	0	0	0	0	68.63	0	0	11.8
2015	7	8	23	23	6	32	0	0	0	0	0	0	0	68.59	0	0	11.8
2015	7	8	23	33	6	32	0	0	0	0	0	0	0	68.58	0	0	11.8
2015	7	8	23	43	6	32	0	0	0	0	0	0	0	68.56	0	0	11.8
2015	7	8	23	53	6	32	0	0	0	0	0	0	0	68.54	0	0	11.8
2015	7	9	0	3	6	32	0	0	0	0	0	0	0	68.52	0	0	11.8
2015	7	9	0	13	6	33	0	0	0	0	0	0	0	68.5	0	0	11.8
2015	7	9	0	23	6	32	0	0	0	0	0	0	0	68.49	0	0	11.8
2015	7	9	0	33	6	33	0	0	0	0	0	0	0	68.45	0	0	11.8
2015	7	9	0	43	6	32	0	0	0	0	0	0	0	68.43	0	0	11.8
2015	7	9	0	53	6	32	0	0	0	0	0	0	0	68.4	0	0	11.8
2015	7	9	1	3	6	32	0	0	0	0	0	0	0	68.38	0	0	11.8
2015	7	9	1	13	6	33	0	0	0	0	0	0	0	68.34	0	0	11.8
2015	7	9	1	23	6	32	0	0	0	0	0	0	0	68.32	0	0	11.8
2015	7	9	1	33	6	32	0	0	0	0	0	0	0	68.31	0	0	11.8
2015	7	9	1	43	6	32	0	0	0	0	0	0	0	68.29	0	0	11.8
2015	7	9	1	53	6	33	0	0	0	0	0	0	0	68.25	0	0	11.8
2015	7	9	2	3	6	32	0	0	0	0	0	0	0	68.23	0	0	11.8
2015	7	9	2	13	6	32	0	0	0	0	0	0	0	68.22	0	0	11.8
2015	7	9	2	23	6	32	0	0	0	0	0	0	0	68.18	0	0	11.8
2015	7	9	2	33	6	32	0	0	0	0	0	0	0	68.14	0	0	11.8
2015	7	9	2	43	6	32	0	0	0	0	0	0	0	68.13	0	0	11.8
2015	7	9	2	53	6	32	0	0	0	0	0	0	0	68.09	0	0	11.8
2015	7	9	3	3	6	33	0	0	0	0	0	0	0	68.05	0	0	11.8
2015	7	9	3	13	6	33	0	0	0	0	0	0	0	68.02	0	0	11.8
2015	7	9	3	23	6	33	0	0	0	0	0	0	0	67.98	0	0	11.8
2015	7	9	3	33	6	32	0	0	0	0	0	0	0	67.95	0	0	11.8
2015	7	9	3	43	6	33	0	0	0	0	0	0	0	67.91	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	9	3	53	6	33	0	0	0	0	0	0	0	67.87	0	0	11.8
2015	7	9	4	3	6	32	0	0	0	0	0	0	0	67.84	0	0	11.8
2015	7	9	4	13	6	33	0	0	0	0	0	0	0	67.8	0	0	11.8
2015	7	9	4	23	6	32	0	0	0	0	0	0	0	67.75	0	0	11.8
2015	7	9	4	33	6	33	0	0	0	0	0	0	0	67.71	0	0	11.8
2015	7	9	4	43	6	33	0	0	0	0	0	0	0	67.68	0	0	11.8
2015	7	9	4	53	6	33	0	0	0	0	0	0	0	67.64	0	0	11.8
2015	7	9	5	3	6	32	0	0	0	0	0	0	0	67.6	0	0	11.8
2015	7	9	5	13	6	32	0	0	0	0	0	0	0	67.57	0	0	11.8
2015	7	9	5	23	6	32	0	0	0	0	0	0	0	67.53	0	0	11.8
2015	7	9	5	33	6	32	0	0	0	0	0	0	0	67.48	0	0	11.8
2015	7	9	5	43	6	33	0	0	0	0	0	0	0	67.44	0	0	11.8
2015	7	9	5	53	6	33	0	0	0	0	0	0	0	67.41	0	0	11.8
2015	7	9	6	3	6	32	0	0	0	0	0	0	0	67.37	0	0	11.8
2015	7	9	6	13	6	33	0	0	0	0	0	0	0	67.35	0	0	11.8
2015	7	9	6	23	6	33	0	0	0	0	0	0	0	67.32	0	0	11.8
2015	7	9	6	33	6	32	0	0	0	0	0	0	0	67.3	0	0	11.8
2015	7	9	6	43	6	32	0	0	0	0	0	0	0	67.26	0	0	11.8
2015	7	9	6	53	6	32	0	0	0	0	0	0	0	67.24	0	0	12
2015	7	9	7	3	6	33	0	0	0	0	0	0	0	67.23	0	0	11.8
2015	7	9	7	13	6	32	0	0	0	0	0	0	0	67.19	0	0	12
2015	7	9	7	23	6	32	0	0	0	0	0	0	0	67.19	0	0	12
2015	7	9	7	33	6	32	0	0	0	0	0	0	0	67.17	0	0	12.2
2015	7	9	7	43	6	32	0	0	0	0	0	0	0	67.15	0	0	12.2
2015	7	9	7	53	6	32	0	0	0	0	0	0	0	67.17	0	0	12.4
2015	7	9	8	3	6	32	0	0	0	0	0	0	0	67.15	0	0	12.4
2015	7	9	8	13	6	33	0	0	0	0	0	0	0	67.17	0	0	12.6
2015	7	9	8	23	6	33	0	0	0	0	0	0	0	67.15	0	0	12.6
2015	7	9	8	33	6	32	0	0	0	0	0	0	0	67.17	0	0	12.8
2015	7	9	8	43	6	33	0	0	0	0	0	0	0	67.17	0	0	12.8
2015	7	9	8	53	6	32	0	0	0	0	0	0	0	67.21	0	0	13
2015	7	9	9	3	6	32	0	0	0	0	0	0	0	67.23	0	0	13
2015	7	9	9	13	6	33	0	0	0	0	0	0	0	67.24	0	0	13
2015	7	9	9	23	6	33	0	0	0	0	0	0	0	67.28	0	0	13.2
2015	7	9	9	33	6	32	0	0	0	0	0	0	0	67.33	0	0	13.4
2015	7	9	9	43	6	32	0	0	0	0	0	0	0	67.32	0	0	13.2
2015	7	9	9	53	6	32	0	0	0	0	0	0	0	67.37	0	0	13.6
2015	7	9	10	3	6	32	0	0	0	0	0	0	0	67.35	0	0	13.6
2015	7	9	10	13	6	32	0	0	0	0	0	0	0	67.33	0	0	13.6
2015	7	9	10	23	6	33	0	0	0	0	0	0	0	67.46	0	0	13.8
2015	7	9	10	33	6	33	0	0	0	0	0	0	0	67.33	0	0	12.6
2015	7	9	10	43	6	32	0	0	0	0	0	0	0	67.3	0	0	12.6
2015	7	9	10	53	6	33	0	0	0	0	0	0	0	67.24	0	0	12.2
2015	7	9	11	3	6	33	0	0	0	0	0	0	0	67.23	0	0	12.2
2015	7	9	11	13	6	33	0	0	0	0	0	0	0	67.21	0	0	12.2
2015	7	9	11	23	6	32	0	0	0	0	0	0	0	67.19	0	0	12.2
2015	7	9	11	33	6	32	0	0	0	0	0	0	0	67.17	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	9	11	43	6	32		0	0	0	0	0	0	67.15	0	0	12
2015	7	9	11	53	6	32		0	0	0	0	0	0	67.14	0	0	12
2015	7	9	12	3	6	33		0	0	0	0	0	0	67.12	0	0	12
2015	7	9	12	13	6	32		0	0	0	0	0	0	67.14	0	0	12
2015	7	9	12	23	6	33		0	0	0	0	0	0	67.12	0	0	12
2015	7	9	12	33	6	32		0	0	0	0	0	0	67.12	0	0	12
2015	7	9	12	43	6	33		0	0	0	0	0	0	67.1	0	0	12
2015	7	9	12	53	6	32		0	0	0	0	0	0	67.12	0	0	12
2015	7	9	13	3	6	32		0	0	0	0	0	0	67.1	0	0	12
2015	7	9	13	13	6	33		0	0	0	0	0	0	67.06	0	0	12
2015	7	9	13	23	6	31		0	0	0	0	0	0	67.05	0	0	12
2015	7	9	13	33	6	33		0	0	0	0	0	0	67.03	0	0	12
2015	7	9	13	43	6	32		0	0	0	0	0	0	67.03	0	0	12
2015	7	9	13	53	6	32		0	0	0	0	0	0	67.06	0	0	12.2
2015	7	9	14	3	6	31		0	0	0	0	0	0	67.17	0	0	13.8
2015	7	9	14	13	6	32		0	0	0	0	0	0	67.32	0	0	13.6
2015	7	9	14	23	6	33		0	0	0	0	0	0	67.48	0	0	13.6
2015	7	9	14	33	6	33		0	0	0	0	0	0	67.53	0	0	14.2
2015	7	9	14	43	6	32		0	0	0	0	0	0	67.55	0	0	14
2015	7	9	14	53	6	32		0	0	0	0	0	0	67.33	0	0	13
2015	7	9	15	3	6	33		0	0	0	0	0	0	67.32	0	0	13.4
2015	7	9	15	13	6	32		0	0	0	0	0	0	67.24	0	0	13.2
2015	7	9	15	23	6	32		0	0	0	0	0	0	67.23	0	0	13.2
2015	7	9	15	33	6	33		0	0	0	0	0	0	67.19	0	0	12.4
2015	7	9	15	43	6	32		0	0	0	0	0	0	67.17	0	0	12.4
2015	7	9	15	53	6	32		0	0	0	0	0	0	67.24	0	0	13.2
2015	7	9	16	3	6	32		0	0	0	0	0	0	67.19	0	0	12.4
2015	7	9	16	13	6	32		0	0	0	0	0	0	67.3	0	0	13.6
2015	7	9	16	23	6	32		0	0	0	0	0	0	67.35	0	0	13.2
2015	7	9	16	33	6	33		0	0	0	0	0	0	67.33	0	0	12.8
2015	7	9	16	43	6	33		0	0	0	0	0	0	67.32	0	0	12.6
2015	7	9	16	53	6	32		0	0	0	0	0	0	67.26	0	0	12.2
2015	7	9	17	3	6	33		0	0	0	0	0	0	67.3	0	0	12.4
2015	7	9	17	13	6	33		0	0	0	0	0	0	67.24	0	0	12.4
2015	7	9	17	23	6	33		0	0	0	0	0	0	67.26	0	0	12.4
2015	7	9	17	33	6	32		0	0	0	0	0	0	67.23	0	0	12.2
2015	7	9	17	43	6	32		0	0	0	0	0	0	67.19	0	0	11.6
2015	7	9	17	53	6	32		0	0	0	0	0	0	67.17	0	0	12
2015	7	9	18	3	6	33		0	0	0	0	0	0	67.17	0	0	11.8
2015	7	9	18	13	6	32		0	0	0	0	0	0	67.17	0	0	11.8
2015	7	9	18	23	6	32		0	0	0	0	0	0	67.17	0	0	11.6
2015	7	9	18	33	6	32		0	0	0	0	0	0	67.17	0	0	12
2015	7	9	18	43	6	32		0	0	0	0	0	0	67.17	0	0	12
2015	7	9	18	53	6	33		0	0	0	0	0	0	67.15	0	0	12
2015	7	9	19	3	6	32		0	0	0	0	0	0	67.14	0	0	12
2015	7	9	19	13	6	32		0	0	0	0	0	0	67.12	0	0	11.8
2015	7	9	19	23	6	33		0	0	0	0	0	0	67.1	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	9	19	33	6	32		0	0	0	0	0	0	67.08	0	0	11.8
2015	7	9	19	43	6	32		0	0	0	0	0	0	67.06	0	0	11.8
2015	7	9	19	53	6	33		0	0	0	0	0	0	67.03	0	0	11.8
2015	7	9	20	3	6	33		0	0	0	0	0	0	67.01	0	0	11.8
2015	7	9	20	13	6	33		0	0	0	0	0	0	66.99	0	0	11.8
2015	7	9	20	23	6	32		0	0	0	0	0	0	66.97	0	0	11.8
2015	7	9	20	33	6	33		0	0	0	0	0	0	66.94	0	0	11.2
2015	7	9	20	43	6	32		0	0	0	0	0	0	66.92	0	0	11
2015	7	9	20	53	6	33		0	0	0	0	0	0	66.9	0	0	11
2015	7	9	21	3	6	33		0	0	0	0	0	0	66.87	0	0	11
2015	7	9	21	13	6	32		0	0	0	0	0	0	66.83	0	0	11
2015	7	9	21	23	6	33		0	0	0	0	0	0	66.79	0	0	10.8
2015	7	9	21	33	6	33		0	0	0	0	0	0	66.76	0	0	11.8
2015	7	9	21	43	6	33		0	0	0	0	0	0	66.74	0	0	11.8
2015	7	9	21	53	6	32		0	0	0	0	0	0	66.7	0	0	11.8
2015	7	9	22	3	6	32		0	0	0	0	0	0	66.67	0	0	11.8
2015	7	9	22	13	6	32		0	0	0	0	0	0	66.63	0	0	11.8
2015	7	9	22	23	6	33		0	0	0	0	0	0	66.6	0	0	11.8
2015	7	9	22	33	6	32		0	0	0	0	0	0	66.56	0	0	11.8
2015	7	9	22	43	6	32		0	0	0	0	0	0	66.52	0	0	11.8
2015	7	9	22	53	6	33		0	0	0	0	0	0	66.47	0	0	11.8
2015	7	9	23	3	6	33		0	0	0	0	0	0	66.43	0	0	11.8
2015	7	9	23	13	6	33		0	0	0	0	0	0	66.4	0	0	11.8
2015	7	9	23	23	6	32		0	0	0	0	0	0	66.36	0	0	11.8
2015	7	9	23	33	6	33		0	0	0	0	0	0	66.31	0	0	11.8
2015	7	9	23	43	6	32		0	0	0	0	0	0	66.27	0	0	11.8
2015	7	9	23	53	6	32		0	0	0	0	0	0	66.22	0	0	11.8
2015	7	10	0	3	6	33		0	0	0	0	0	0	66.18	0	0	11.6
2015	7	10	0	13	6	33		0	0	0	0	0	0	66.13	0	0	11.6
2015	7	10	0	23	6	33		0	0	0	0	0	0	66.09	0	0	11.6
2015	7	10	0	33	6	32		0	0	0	0	0	0	66.04	0	0	11.6
2015	7	10	0	43	6	33		0	0	0	0	0	0	66	0	0	11.6
2015	7	10	0	53	6	33		0	0	0	0	0	0	65.97	0	0	11.6
2015	7	10	1	3	6	32		0	0	0	0	0	0	65.91	0	0	11.6
2015	7	10	1	13	6	32		0	0	0	0	0	0	65.88	0	0	11.6
2015	7	10	1	23	6	32		0	0	0	0	0	0	65.82	0	0	11.6
2015	7	10	1	33	6	33		0	0	0	0	0	0	65.79	0	0	11.6
2015	7	10	1	43	6	33		0	0	0	0	0	0	65.73	0	0	11.6
2015	7	10	1	53	6	33		0	0	0	0	0	0	65.7	0	0	11.6
2015	7	10	2	3	6	33		0	0	0	0	0	0	65.64	0	0	11.6
2015	7	10	2	13	6	32		0	0	0	0	0	0	65.59	0	0	11.6
2015	7	10	2	23	6	33		0	0	0	0	0	0	65.53	0	0	11.6
2015	7	10	2	33	6	33		0	0	0	0	0	0	65.5	0	0	11.6
2015	7	10	2	43	6	33		0	0	0	0	0	0	65.44	0	0	11.6
2015	7	10	2	53	6	32		0	0	0	0	0	0	65.41	0	0	11.6
2015	7	10	3	3	6	33		0	0	0	0	0	0	65.37	0	0	11.6
2015	7	10	3	13	6	33		0	0	0	0	0	0	65.32	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	10	3	23	6	33		0	0	0	0	0	0	65.28	0	0	11.6
2015	7	10	3	33	6	33		0	0	0	0	0	0	65.25	0	0	11.6
2015	7	10	3	43	6	32		0	0	0	0	0	0	65.19	0	0	11
2015	7	10	3	53	6	33		0	0	0	0	0	0	65.14	0	0	11
2015	7	10	4	3	6	33		0	0	0	0	0	0	65.1	0	0	11
2015	7	10	4	13	6	32		0	0	0	0	0	0	65.05	0	0	11
2015	7	10	4	23	6	32		0	0	0	0	0	0	65.01	0	0	11
2015	7	10	4	33	6	32		0	0	0	0	0	0	64.96	0	0	11.8
2015	7	10	4	43	6	33		0	0	0	0	0	0	64.92	0	0	11.8
2015	7	10	4	53	6	32		0	0	0	0	0	0	64.87	0	0	11.6
2015	7	10	5	3	6	33		0	0	0	0	0	0	64.81	0	0	11.6
2015	7	10	5	13	6	32		0	0	0	0	0	0	64.78	0	0	11.6
2015	7	10	5	23	6	33		0	0	0	0	0	0	64.74	0	0	11.6
2015	7	10	5	33	6	33		0	0	0	0	0	0	64.69	0	0	11.6
2015	7	10	5	43	6	32		0	0	0	0	0	0	64.65	0	0	11.6
2015	7	10	5	53	6	33		0	0	0	0	0	0	64.62	0	0	11.6
2015	7	10	6	3	6	32		0	0	0	0	0	0	64.56	0	0	11.6
2015	7	10	6	13	6	34		0	0	0	0	0	0	64.53	0	0	11.6
2015	7	10	6	23	6	33		0	0	0	0	0	0	64.47	0	0	11.8
2015	7	10	6	33	6	33		0	0	0	0	0	0	64.45	0	0	11.8
2015	7	10	6	43	6	32		0	0	0	0	0	0	64.4	0	0	11.8
2015	7	10	6	53	6	33		0	0	0	0	0	0	64.36	0	0	11.8
2015	7	10	7	3	6	33		0	0	0	0	0	0	64.33	0	0	11.8
2015	7	10	7	13	6	33		0	0	0	0	0	0	64.29	0	0	11.8
2015	7	10	7	23	6	32		0	0	0	0	0	0	64.27	0	0	12
2015	7	10	7	33	6	33		0	0	0	0	0	0	64.27	0	0	12
2015	7	10	7	43	6	32		0	0	0	0	0	0	64.26	0	0	12
2015	7	10	7	53	6	32		0	0	0	0	0	0	64.26	0	0	12.2
2015	7	10	8	3	6	33		0	0	0	0	0	0	64.26	0	0	12.4
2015	7	10	8	13	6	33		0	0	0	0	0	0	64.27	0	0	13.2
2015	7	10	8	23	6	32		0	0	0	0	0	0	64.27	0	0	13.4
2015	7	10	8	33	6	33		0	0	0	0	0	0	64.29	0	0	13.2
2015	7	10	8	43	6	32		0	0	0	0	0	0	64.31	0	0	13.2
2015	7	10	8	53	6	32		0	0	0	0	0	0	64.33	0	0	13.2
2015	7	10	9	3	6	33		0	0	0	0	0	0	64.36	0	0	13.4
2015	7	10	9	13	6	32		0	0	0	0	0	0	64.38	0	0	13.6
2015	7	10	9	23	6	33		0	0	0	0	0	0	64.42	0	0	13.4
2015	7	10	9	33	6	33		0	0	0	0	0	0	64.45	0	0	13.4
2015	7	10	9	43	6	32		0	0	0	0	0	0	64.49	0	0	13.4
2015	7	10	9	53	6	33		0	0	0	0	0	0	64.54	0	0	13.2
2015	7	10	10	3	6	33		0	0	0	0	0	0	64.6	0	0	13.2
2015	7	10	10	13	6	33		0	0	0	0	0	0	64.65	0	0	13.2
2015	7	10	10	23	6	33		0	0	0	0	0	0	64.71	0	0	13.2
2015	7	10	10	33	6	34		0	0	0	0	0	0	64.76	0	0	13.6
2015	7	10	10	43	6	33		0	0	0	0	0	0	64.83	0	0	14
2015	7	10	10	53	6	32		0	0	0	0	0	0	64.89	0	0	14
2015	7	10	11	3	6	33		0	0	0	0	0	0	64.94	0	0	14

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	10	11	13	6	32	0	0	0	0	0	0	0	64.99	0	0	14
2015	7	10	11	23	6	33	0	0	0	0	0	0	0	65.07	0	0	14.2
2015	7	10	11	33	6	32	0	0	0	0	0	0	0	65.12	0	0	14.2
2015	7	10	11	43	6	33	0	0	0	0	0	0	0	65.19	0	0	14.2
2015	7	10	11	53	6	33	0	0	0	0	0	0	0	65.26	0	0	14.2
2015	7	10	12	3	6	33	0	0	0	0	0	0	0	65.34	0	0	14.2
2015	7	10	12	13	6	33	0	0	0	0	0	0	0	65.41	0	0	14.2
2015	7	10	12	23	6	33	0	0	0	0	0	0	0	65.48	0	0	14.2
2015	7	10	12	33	6	33	0	0	0	0	0	0	0	65.55	0	0	14.2
2015	7	10	12	43	6	33	0	0	0	0	0	0	0	65.61	0	0	14.2
2015	7	10	12	53	6	32	0	0	0	0	0	0	0	65.7	0	0	14.2
2015	7	10	13	3	6	33	0	0	0	0	0	0	0	65.79	0	0	14.2
2015	7	10	13	13	6	32	0	0	0	0	0	0	0	65.68	0	0	13.6
2015	7	10	13	23	6	32	0	0	0	0	0	0	0	65.89	0	0	14.2
2015	7	10	13	33	6	33	0	0	0	0	0	0	0	65.8	0	0	13.6
2015	7	10	13	43	6	32	0	0	0	0	0	0	0	65.73	0	0	13.2
2015	7	10	13	53	6	32	0	0	0	0	0	0	0	65.7	0	0	13.2
2015	7	10	14	3	6	32	0	0	0	0	0	0	0	65.7	0	0	13
2015	7	10	14	13	6	33	0	0	0	0	0	0	0	65.7	0	0	12.8
2015	7	10	14	23	6	33	0	0	0	0	0	0	0	65.71	0	0	13.2
2015	7	10	14	33	6	33	0	0	0	0	0	0	0	65.73	0	0	12.4
2015	7	10	14	43	6	32	0	0	0	0	0	0	0	65.75	0	0	12
2015	7	10	14	53	6	33	0	0	0	0	0	0	0	65.77	0	0	12.2
2015	7	10	15	3	6	33	0	0	0	0	0	0	0	65.8	0	0	12
2015	7	10	15	13	6	32	0	0	0	0	0	0	0	65.82	0	0	12.2
2015	7	10	15	23	6	33	0	0	0	0	0	0	0	65.84	0	0	11.8
2015	7	10	15	33	6	32	0	0	0	0	0	0	0	65.88	0	0	11.8
2015	7	10	15	43	6	32	0	0	0	0	0	0	0	65.89	0	0	11.8
2015	7	10	15	53	6	32	0	0	0	0	0	0	0	65.89	0	0	12
2015	7	10	16	3	6	33	0	0	0	0	0	0	0	65.91	0	0	11.6
2015	7	10	16	13	6	32	0	0	0	0	0	0	0	65.91	0	0	11.6
2015	7	10	16	23	6	33	0	0	0	0	0	0	0	65.93	0	0	11.4
2015	7	10	16	33	6	33	0	0	0	0	0	0	0	65.95	0	0	11.4
2015	7	10	16	43	6	33	0	0	0	0	0	0	0	65.93	0	0	11.4
2015	7	10	16	53	6	32	0	0	0	0	0	0	0	65.93	0	0	11.2
2015	7	10	17	3	6	32	0	0	0	0	0	0	0	65.93	0	0	11.4
2015	7	10	17	13	6	32	0	0	0	0	0	0	0	65.91	0	0	11.2
2015	7	10	17	23	6	32	0	0	0	0	0	0	0	65.89	0	0	11.2
2015	7	10	17	33	6	33	0	0	0	0	0	0	0	65.89	0	0	11.4
2015	7	10	17	43	6	32	0	0	0	0	0	0	0	65.89	0	0	11.4
2015	7	10	17	53	6	32	0	0	0	0	0	0	0	65.88	0	0	11.4
2015	7	10	18	3	6	33	0	0	0	0	0	0	0	65.88	0	0	11.4
2015	7	10	18	13	6	33	0	0	0	0	0	0	0	65.86	0	0	11.4
2015	7	10	18	23	6	33	0	0	0	0	0	0	0	65.86	0	0	11.2
2015	7	10	18	33	6	33	0	0	0	0	0	0	0	65.86	0	0	11.2
2015	7	10	18	43	6	32	0	0	0	0	0	0	0	65.84	0	0	11.4
2015	7	10	18	53	6	33	0	0	0	0	0	0	0	65.82	0	0	11.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	10	19	3	6	32	0	0	0	0	0	0	0	65.82	0	0	11.2
2015	7	10	19	13	6	33	0	0	0	0	0	0	0	65.8	0	0	11.2
2015	7	10	19	23	6	33	0	0	0	0	0	0	0	65.79	0	0	11
2015	7	10	19	33	6	33	0	0	0	0	0	0	0	65.79	0	0	11
2015	7	10	19	43	6	33	0	0	0	0	0	0	0	65.77	0	0	10.8
2015	7	10	19	53	6	32	0	0	0	0	0	0	0	65.75	0	0	10.8
2015	7	10	20	3	6	32	0	0	0	0	0	0	0	65.75	0	0	10.6
2015	7	10	20	13	6	32	0	0	0	0	0	0	0	65.73	0	0	10.6
2015	7	10	20	23	6	33	0	0	0	0	0	0	0	65.71	0	0	10.6
2015	7	10	20	33	6	32	0	0	0	0	0	0	0	65.7	0	0	10.6
2015	7	10	20	43	6	32	0	0	0	0	0	0	0	65.7	0	0	10.6
2015	7	10	20	53	6	32	0	0	0	0	0	0	0	65.68	0	0	10.6
2015	7	10	21	3	6	33	0	0	0	0	0	0	0	65.66	0	0	10.6
2015	7	10	21	13	6	32	0	0	0	0	0	0	0	65.64	0	0	10.4
2015	7	10	21	23	6	33	0	0	0	0	0	0	0	65.62	0	0	10.4
2015	7	10	21	33	6	32	0	0	0	0	0	0	0	65.61	0	0	11.8
2015	7	10	21	43	6	33	0	0	0	0	0	0	0	65.59	0	0	11.8
2015	7	10	21	53	6	33	0	0	0	0	0	0	0	65.57	0	0	11.8
2015	7	10	22	3	6	32	0	0	0	0	0	0	0	65.55	0	0	11.8
2015	7	10	22	13	6	33	0	0	0	0	0	0	0	65.53	0	0	11.8
2015	7	10	22	23	6	32	0	0	0	0	0	0	0	65.52	0	0	11.8
2015	7	10	22	33	6	32	0	0	0	0	0	0	0	65.48	0	0	11.8
2015	7	10	22	43	6	32	0	0	0	0	0	0	0	65.46	0	0	11.8
2015	7	10	22	53	6	32	0	0	0	0	0	0	0	65.44	0	0	11.8
2015	7	10	23	3	6	33	0	0	0	0	0	0	0	65.43	0	0	11.8
2015	7	10	23	13	6	32	0	0	0	0	0	0	0	65.39	0	0	11.8
2015	7	10	23	23	6	33	0	0	0	0	0	0	0	65.37	0	0	11.8
2015	7	10	23	33	6	33	0	0	0	0	0	0	0	65.35	0	0	11.8
2015	7	10	23	43	6	32	0	0	0	0	0	0	0	65.32	0	0	11.8
2015	7	10	23	53	6	33	0	0	0	0	0	0	0	65.28	0	0	11.8
2015	7	11	0	3	6	33	0	0	0	0	0	0	0	65.25	0	0	11.8
2015	7	11	0	13	6	32	0	0	0	0	0	0	0	65.23	0	0	11.8
2015	7	11	0	23	6	33	0	0	0	0	0	0	0	65.19	0	0	11.8
2015	7	11	0	33	6	32	0	0	0	0	0	0	0	65.16	0	0	11.8
2015	7	11	0	43	6	32	0	0	0	0	0	0	0	65.14	0	0	11.8
2015	7	11	0	53	6	32	0	0	0	0	0	0	0	65.1	0	0	11.8
2015	7	11	1	3	6	32	0	0	0	0	0	0	0	65.08	0	0	11.8
2015	7	11	1	13	6	32	0	0	0	0	0	0	0	65.03	0	0	11.6
2015	7	11	1	23	6	33	0	0	0	0	0	0	0	65.01	0	0	11.6
2015	7	11	1	33	6	32	0	0	0	0	0	0	0	64.98	0	0	11.6
2015	7	11	1	43	6	33	0	0	0	0	0	0	0	64.96	0	0	11.6
2015	7	11	1	53	6	33	0	0	0	0	0	0	0	64.92	0	0	11.6
2015	7	11	2	3	6	33	0	0	0	0	0	0	0	64.89	0	0	11.6
2015	7	11	2	13	6	33	0	0	0	0	0	0	0	64.87	0	0	11.6
2015	7	11	2	23	6	33	0	0	0	0	0	0	0	64.83	0	0	11.6
2015	7	11	2	33	6	33	0	0	0	0	0	0	0	64.8	0	0	11.6
2015	7	11	2	43	6	32	0	0	0	0	0	0	0	64.76	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	11	2	53	6	32		0	0	0	0	0	0	64.72	0	0	11.6
2015	7	11	3	3	6	33		0	0	0	0	0	0	64.69	0	0	11.6
2015	7	11	3	13	6	32		0	0	0	0	0	0	64.63	0	0	11.6
2015	7	11	3	23	6	33		0	0	0	0	0	0	64.6	0	0	11.6
2015	7	11	3	33	6	33		0	0	0	0	0	0	64.58	0	0	11.6
2015	7	11	3	43	6	32		0	0	0	0	0	0	64.54	0	0	11.6
2015	7	11	3	53	6	32		0	0	0	0	0	0	64.51	0	0	11.6
2015	7	11	4	3	6	32		0	0	0	0	0	0	64.47	0	0	11.6
2015	7	11	4	13	6	33		0	0	0	0	0	0	64.42	0	0	11.6
2015	7	11	4	23	6	33		0	0	0	0	0	0	64.4	0	0	11.6
2015	7	11	4	33	6	33		0	0	0	0	0	0	64.35	0	0	11.6
2015	7	11	4	43	6	33		0	0	0	0	0	0	64.31	0	0	11.6
2015	7	11	4	53	6	33		0	0	0	0	0	0	64.26	0	0	11.6
2015	7	11	5	3	6	33		0	0	0	0	0	0	64.22	0	0	11.6
2015	7	11	5	13	6	32		0	0	0	0	0	0	64.17	0	0	11.6
2015	7	11	5	23	6	33		0	0	0	0	0	0	64.11	0	0	11.6
2015	7	11	5	33	6	33		0	0	0	0	0	0	64.06	0	0	11.6
2015	7	11	5	43	6	33		0	0	0	0	0	0	64.04	0	0	11.6
2015	7	11	5	53	6	32		0	0	0	0	0	0	63.99	0	0	11.6
2015	7	11	6	3	6	33		0	0	0	0	0	0	63.93	0	0	11.6
2015	7	11	6	13	6	32		0	0	0	0	0	0	63.9	0	0	11.6
2015	7	11	6	23	6	33		0	0	0	0	0	0	63.84	0	0	11.6
2015	7	11	6	33	6	33		0	0	0	0	0	0	63.81	0	0	11.6
2015	7	11	6	43	6	32		0	0	0	0	0	0	63.77	0	0	11.6
2015	7	11	6	53	6	33		0	0	0	0	0	0	63.73	0	0	11.8
2015	7	11	7	3	6	33		0	0	0	0	0	0	63.68	0	0	11.8
2015	7	11	7	13	6	33		0	0	0	0	0	0	63.66	0	0	11.8
2015	7	11	7	23	6	33		0	0	0	0	0	0	63.64	0	0	11.8
2015	7	11	7	33	6	34		0	0	0	0	0	0	63.63	0	0	11.8
2015	7	11	7	43	6	33		0	0	0	0	0	0	63.63	0	0	12
2015	7	11	7	53	6	33		0	0	0	0	0	0	63.63	0	0	12
2015	7	11	8	3	6	33		0	0	0	0	0	0	63.63	0	0	12.2
2015	7	11	8	13	6	33		0	0	0	0	0	0	63.63	0	0	12.2
2015	7	11	8	23	6	33		0	0	0	0	0	0	63.64	0	0	13.8
2015	7	11	8	33	6	33		0	0	0	0	0	0	63.64	0	0	13.6
2015	7	11	8	43	6	32		0	0	0	0	0	0	63.64	0	0	13.6
2015	7	11	8	53	6	33		0	0	0	0	0	0	63.66	0	0	13.4
2015	7	11	9	3	6	33		0	0	0	0	0	0	63.68	0	0	13.8
2015	7	11	9	13	6	33		0	0	0	0	0	0	63.72	0	0	13.4
2015	7	11	9	23	6	33		0	0	0	0	0	0	63.75	0	0	13.8
2015	7	11	9	33	6	33		0	0	0	0	0	0	63.79	0	0	13.6
2015	7	11	9	43	6	33		0	0	0	0	0	0	63.84	0	0	13.6
2015	7	11	9	53	6	33		0	0	0	0	0	0	63.9	0	0	13.6
2015	7	11	10	3	6	33		0	0	0	0	0	0	63.93	0	0	13.6
2015	7	11	10	13	6	33		0	0	0	0	0	0	63.99	0	0	13.6
2015	7	11	10	23	6	33		0	0	0	0	0	0	64.06	0	0	13.6
2015	7	11	10	33	6	32		0	0	0	0	0	0	64.11	0	0	14

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	11	10	43	6	33	0	0	0	0	0	0	0	64.18	0	0	14.2
2015	7	11	10	53	6	34	0	0	0	0	0	0	0	64.24	0	0	14.2
2015	7	11	11	3	6	33	0	0	0	0	0	0	0	64.29	0	0	14.2
2015	7	11	11	13	6	33	0	0	0	0	0	0	0	64.35	0	0	14.2
2015	7	11	11	23	6	33	0	0	0	0	0	0	0	64.4	0	0	14.2
2015	7	11	11	33	6	33	0	0	0	0	0	0	0	64.47	0	0	14.2
2015	7	11	11	43	6	33	0	0	0	0	0	0	0	64.56	0	0	14.2
2015	7	11	11	53	6	33	0	0	0	0	0	0	0	64.62	0	0	14.2
2015	7	11	12	3	6	33	0	0	0	0	0	0	0	64.69	0	0	14.2
2015	7	11	12	13	6	32	0	0	0	0	0	0	0	64.76	0	0	14.2
2015	7	11	12	23	6	33	0	0	0	0	0	0	0	64.81	0	0	14.2
2015	7	11	12	33	6	33	0	0	0	0	0	0	0	64.9	0	0	13.8
2015	7	11	12	43	6	33	0	0	0	0	0	0	0	64.96	0	0	13.8
2015	7	11	12	53	6	33	0	0	0	0	0	0	0	65.03	0	0	13.8
2015	7	11	13	3	6	32	0	0	0	0	0	0	0	65.1	0	0	13.6
2015	7	11	13	13	6	33	0	0	0	0	0	0	0	65.19	0	0	13.6
2015	7	11	13	23	6	33	0	0	0	0	0	0	0	65.26	0	0	13.4
2015	7	11	13	33	6	33	0	0	0	0	0	0	0	65.3	0	0	13.4
2015	7	11	13	43	6	32	0	0	0	0	0	0	0	65.37	0	0	14
2015	7	11	13	53	6	33	0	0	0	0	0	0	0	65.43	0	0	14
2015	7	11	14	3	6	33	0	0	0	0	0	0	0	65.5	0	0	14
2015	7	11	14	13	6	34	0	0	0	0	0	0	0	65.44	0	0	14
2015	7	11	14	23	6	33	0	0	0	0	0	0	0	65.53	0	0	14
2015	7	11	14	33	6	33	0	0	0	0	0	0	0	65.57	0	0	14
2015	7	11	14	43	6	32	0	0	0	0	0	0	0	65.52	0	0	13.4
2015	7	11	14	53	6	33	0	0	0	0	0	0	0	65.52	0	0	13.4
2015	7	11	15	3	6	33	0	0	0	0	0	0	0	65.53	0	0	13.4
2015	7	11	15	13	6	33	0	0	0	0	0	0	0	65.62	0	0	13.6
2015	7	11	15	23	6	32	0	0	0	0	0	0	0	65.59	0	0	13
2015	7	11	15	33	6	32	0	0	0	0	0	0	0	65.64	0	0	13.4
2015	7	11	15	43	6	33	0	0	0	0	0	0	0	65.7	0	0	13.4
2015	7	11	15	53	6	32	0	0	0	0	0	0	0	65.75	0	0	13.4
2015	7	11	16	3	6	33	0	0	0	0	0	0	0	65.8	0	0	13.4
2015	7	11	16	13	6	33	0	0	0	0	0	0	0	65.84	0	0	13.2
2015	7	11	16	23	6	33	0	0	0	0	0	0	0	65.88	0	0	13.4
2015	7	11	16	33	6	33	0	0	0	0	0	0	0	65.88	0	0	13
2015	7	11	16	43	6	32	0	0	0	0	0	0	0	65.86	0	0	13
2015	7	11	16	53	6	32	0	0	0	0	0	0	0	65.84	0	0	12.8
2015	7	11	17	3	6	32	0	0	0	0	0	0	0	65.84	0	0	12.8
2015	7	11	17	13	6	33	0	0	0	0	0	0	0	65.82	0	0	11.8
2015	7	11	17	23	6	32	0	0	0	0	0	0	0	65.79	0	0	11.2
2015	7	11	17	33	6	32	0	0	0	0	0	0	0	65.79	0	0	11.2
2015	7	11	17	43	6	32	0	0	0	0	0	0	0	65.77	0	0	11
2015	7	11	17	53	6	33	0	0	0	0	0	0	0	65.77	0	0	11
2015	7	11	18	3	6	33	0	0	0	0	0	0	0	65.77	0	0	11
2015	7	11	18	13	6	33	0	0	0	0	0	0	0	65.77	0	0	11
2015	7	11	18	23	6	33	0	0	0	0	0	0	0	65.79	0	0	11

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	11	18	33	6	33		0	0	0	0	0	0	65.77	0	0	11
2015	7	11	18	43	6	33		0	0	0	0	0	0	65.77	0	0	10.8
2015	7	11	18	53	6	32		0	0	0	0	0	0	65.77	0	0	10.8
2015	7	11	19	3	6	33		0	0	0	0	0	0	65.75	0	0	10.8
2015	7	11	19	13	6	32		0	0	0	0	0	0	65.75	0	0	11
2015	7	11	19	23	6	32		0	0	0	0	0	0	65.75	0	0	10.8
2015	7	11	19	33	6	32		0	0	0	0	0	0	65.75	0	0	11.8
2015	7	11	19	43	6	32		0	0	0	0	0	0	65.73	0	0	11.8
2015	7	11	19	53	6	33		0	0	0	0	0	0	65.73	0	0	11.8
2015	7	11	20	3	6	33		0	0	0	0	0	0	65.71	0	0	11.8
2015	7	11	20	13	6	33		0	0	0	0	0	0	65.71	0	0	11.8
2015	7	11	20	23	6	32		0	0	0	0	0	0	65.71	0	0	11.8
2015	7	11	20	33	6	33		0	0	0	0	0	0	65.7	0	0	11
2015	7	11	20	43	6	33		0	0	0	0	0	0	65.7	0	0	11
2015	7	11	20	53	6	32		0	0	0	0	0	0	65.7	0	0	11
2015	7	11	21	3	6	33		0	0	0	0	0	0	65.68	0	0	11
2015	7	11	21	13	6	33		0	0	0	0	0	0	65.66	0	0	11
2015	7	11	21	23	6	32		0	0	0	0	0	0	65.66	0	0	11
2015	7	11	21	33	6	32		0	0	0	0	0	0	65.64	0	0	10.6
2015	7	11	21	43	6	33		0	0	0	0	0	0	65.64	0	0	10.6
2015	7	11	21	53	6	33		0	0	0	0	0	0	65.64	0	0	10.6
2015	7	11	22	3	6	33		0	0	0	0	0	0	65.61	0	0	10.6
2015	7	11	22	13	6	33		0	0	0	0	0	0	65.59	0	0	10.6
2015	7	11	22	23	6	33		0	0	0	0	0	0	65.59	0	0	10.6
2015	7	11	22	33	6	33		0	0	0	0	0	0	65.57	0	0	10.6
2015	7	11	22	43	6	33		0	0	0	0	0	0	65.59	0	0	10.6
2015	7	11	22	53	6	33		0	0	0	0	0	0	65.57	0	0	10.6
2015	7	11	23	3	6	32		0	0	0	0	0	0	65.55	0	0	10.6
2015	7	11	23	13	6	32		0	0	0	0	0	0	65.55	0	0	10.4
2015	7	11	23	23	6	34		0	0	0	0	0	0	65.55	0	0	10.6
2015	7	11	23	33	6	33		0	0	0	0	0	0	65.53	0	0	10.8
2015	7	11	23	43	6	33		0	0	0	0	0	0	65.53	0	0	10.8
2015	7	11	23	53	6	33		0	0	0	0	0	0	65.52	0	0	10.8
2015	7	12	0	3	6	33		0	0	0	0	0	0	65.5	0	0	10.8
2015	7	12	0	13	6	32		0	0	0	0	0	0	65.5	0	0	10.8
2015	7	12	0	23	6	33		0	0	0	0	0	0	65.48	0	0	10.8
2015	7	12	0	33	6	33		0	0	0	0	0	0	65.48	0	0	11
2015	7	12	0	43	6	33		0	0	0	0	0	0	65.46	0	0	11
2015	7	12	0	53	6	33		0	0	0	0	0	0	65.44	0	0	11
2015	7	12	1	3	6	33		0	0	0	0	0	0	65.43	0	0	10.8
2015	7	12	1	13	6	33		0	0	0	0	0	0	65.43	0	0	10.8
2015	7	12	1	23	6	33		0	0	0	0	0	0	65.41	0	0	10.8
2015	7	12	1	33	6	33		0	0	0	0	0	0	65.41	0	0	11
2015	7	12	1	43	6	32		0	0	0	0	0	0	65.39	0	0	11
2015	7	12	1	53	6	33		0	0	0	0	0	0	65.37	0	0	11
2015	7	12	2	3	6	33		0	0	0	0	0	0	65.35	0	0	11
2015	7	12	2	13	6	33		0	0	0	0	0	0	65.34	0	0	10.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	12	2	23	6	33		0	0	0	0	0	0	65.32	0	0	10.8
2015	7	12	2	33	6	33		0	0	0	0	0	0	65.32	0	0	11
2015	7	12	2	43	6	32		0	0	0	0	0	0	65.28	0	0	11
2015	7	12	2	53	6	32		0	0	0	0	0	0	65.28	0	0	11
2015	7	12	3	3	6	32		0	0	0	0	0	0	65.25	0	0	11
2015	7	12	3	13	6	33		0	0	0	0	0	0	65.23	0	0	11
2015	7	12	3	23	6	32		0	0	0	0	0	0	65.19	0	0	11
2015	7	12	3	33	6	32		0	0	0	0	0	0	65.17	0	0	11
2015	7	12	3	43	6	33		0	0	0	0	0	0	65.16	0	0	11
2015	7	12	3	53	6	32		0	0	0	0	0	0	65.12	0	0	11
2015	7	12	4	3	6	33		0	0	0	0	0	0	65.1	0	0	11
2015	7	12	4	13	6	33		0	0	0	0	0	0	65.07	0	0	11
2015	7	12	4	23	6	32		0	0	0	0	0	0	65.03	0	0	11
2015	7	12	4	33	6	33		0	0	0	0	0	0	65.01	0	0	11
2015	7	12	4	43	6	33		0	0	0	0	0	0	64.98	0	0	11
2015	7	12	4	53	6	33		0	0	0	0	0	0	64.94	0	0	11
2015	7	12	5	3	6	33		0	0	0	0	0	0	64.9	0	0	11
2015	7	12	5	13	6	33		0	0	0	0	0	0	64.85	0	0	11
2015	7	12	5	23	6	33		0	0	0	0	0	0	64.81	0	0	11
2015	7	12	5	33	6	32		0	0	0	0	0	0	64.78	0	0	11
2015	7	12	5	43	6	33		0	0	0	0	0	0	64.74	0	0	11
2015	7	12	5	53	6	32		0	0	0	0	0	0	64.71	0	0	11
2015	7	12	6	3	6	33		0	0	0	0	0	0	64.67	0	0	11
2015	7	12	6	13	6	33		0	0	0	0	0	0	64.62	0	0	11
2015	7	12	6	23	6	33		0	0	0	0	0	0	64.56	0	0	11
2015	7	12	6	33	6	34		0	0	0	0	0	0	64.54	0	0	11.8
2015	7	12	6	43	6	32		0	0	0	0	0	0	64.49	0	0	11.8
2015	7	12	6	53	6	32		0	0	0	0	0	0	64.45	0	0	11.8
2015	7	12	7	3	6	33		0	0	0	0	0	0	64.4	0	0	11.8
2015	7	12	7	13	6	33		0	0	0	0	0	0	64.38	0	0	11.8
2015	7	12	7	23	6	33		0	0	0	0	0	0	64.36	0	0	12
2015	7	12	7	33	6	33		0	0	0	0	0	0	64.35	0	0	12
2015	7	12	7	43	6	33		0	0	0	0	0	0	64.33	0	0	12
2015	7	12	7	53	6	33		0	0	0	0	0	0	64.33	0	0	12.8
2015	7	12	8	3	6	34		0	0	0	0	0	0	64.33	0	0	13
2015	7	12	8	13	6	32		0	0	0	0	0	0	64.33	0	0	13.4
2015	7	12	8	23	6	33		0	0	0	0	0	0	64.33	0	0	13.4
2015	7	12	8	33	6	33		0	0	0	0	0	0	64.35	0	0	13.2
2015	7	12	8	43	6	33		0	0	0	0	0	0	64.35	0	0	13.4
2015	7	12	8	53	6	33		0	0	0	0	0	0	64.38	0	0	13.6
2015	7	12	9	3	6	32		0	0	0	0	0	0	64.4	0	0	13.6
2015	7	12	9	13	6	33		0	0	0	0	0	0	64.42	0	0	13.4
2015	7	12	9	23	6	33		0	0	0	0	0	0	64.44	0	0	13.6
2015	7	12	9	33	6	33		0	0	0	0	0	0	64.47	0	0	13.4
2015	7	12	9	43	6	33		0	0	0	0	0	0	64.53	0	0	13.6
2015	7	12	9	53	6	33		0	0	0	0	0	0	64.56	0	0	13.4
2015	7	12	10	3	6	33		0	0	0	0	0	0	64.6	0	0	13.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	12	10	13	6	33		0	0	0	0	0	0	64.65	0	0	13.4
2015	7	12	10	23	6	32		0	0	0	0	0	0	64.71	0	0	13.4
2015	7	12	10	33	6	33		0	0	0	0	0	0	64.74	0	0	13.4
2015	7	12	10	43	6	32		0	0	0	0	0	0	64.8	0	0	13.2
2015	7	12	10	53	6	32		0	0	0	0	0	0	64.85	0	0	13.2
2015	7	12	11	3	6	33		0	0	0	0	0	0	64.92	0	0	13.2
2015	7	12	11	13	6	33		0	0	0	0	0	0	64.96	0	0	13.2
2015	7	12	11	23	6	33		0	0	0	0	0	0	65.01	0	0	13.4
2015	7	12	11	33	6	33		0	0	0	0	0	0	65.08	0	0	13.4
2015	7	12	11	43	6	33		0	0	0	0	0	0	65.14	0	0	13.4
2015	7	12	11	53	6	33		0	0	0	0	0	0	65.21	0	0	13.4
2015	7	12	12	3	6	32		0	0	0	0	0	0	65.1	0	0	13
2015	7	12	12	13	6	33		0	0	0	0	0	0	65.17	0	0	13.4
2015	7	12	12	23	6	33		0	0	0	0	0	0	65.35	0	0	13.2
2015	7	12	12	33	6	33		0	0	0	0	0	0	65.41	0	0	14
2015	7	12	12	43	6	33		0	0	0	0	0	0	65.52	0	0	14
2015	7	12	12	53	6	32		0	0	0	0	0	0	65.59	0	0	13.4
2015	7	12	13	3	6	33		0	0	0	0	0	0	65.62	0	0	13.4
2015	7	12	13	13	6	32		0	0	0	0	0	0	65.7	0	0	13.4
2015	7	12	13	23	6	33		0	0	0	0	0	0	65.77	0	0	13.4
2015	7	12	13	33	6	33		0	0	0	0	0	0	65.82	0	0	13.2
2015	7	12	13	43	6	32		0	0	0	0	0	0	65.89	0	0	13.2
2015	7	12	13	53	6	33		0	0	0	0	0	0	65.93	0	0	13.2
2015	7	12	14	3	6	33		0	0	0	0	0	0	66	0	0	13.2
2015	7	12	14	13	6	33		0	0	0	0	0	0	66.04	0	0	13.2
2015	7	12	14	23	6	32		0	0	0	0	0	0	66.09	0	0	13.2
2015	7	12	14	33	6	33		0	0	0	0	0	0	66.15	0	0	13.2
2015	7	12	14	43	6	33		0	0	0	0	0	0	66.18	0	0	13
2015	7	12	14	53	6	32		0	0	0	0	0	0	66.25	0	0	13
2015	7	12	15	3	6	32		0	0	0	0	0	0	66.27	0	0	13
2015	7	12	15	13	6	33		0	0	0	0	0	0	66.33	0	0	13.2
2015	7	12	15	23	6	33		0	0	0	0	0	0	66.36	0	0	13
2015	7	12	15	33	6	33		0	0	0	0	0	0	66.4	0	0	13.2
2015	7	12	15	43	6	33		0	0	0	0	0	0	66.42	0	0	13.2
2015	7	12	15	53	6	32		0	0	0	0	0	0	66.45	0	0	13.2
2015	7	12	16	3	6	32		0	0	0	0	0	0	66.47	0	0	13
2015	7	12	16	13	6	32		0	0	0	0	0	0	66.51	0	0	13
2015	7	12	16	23	6	33		0	0	0	0	0	0	66.52	0	0	13
2015	7	12	16	33	6	32		0	0	0	0	0	0	66.54	0	0	12.8
2015	7	12	16	43	6	33		0	0	0	0	0	0	66.52	0	0	12.8
2015	7	12	16	53	6	33		0	0	0	0	0	0	66.54	0	0	12.6
2015	7	12	17	3	6	32		0	0	0	0	0	0	66.54	0	0	12.6
2015	7	12	17	13	6	32		0	0	0	0	0	0	66.54	0	0	12.4
2015	7	12	17	23	6	32		0	0	0	0	0	0	66.54	0	0	12.4
2015	7	12	17	33	6	32		0	0	0	0	0	0	66.52	0	0	12.2
2015	7	12	17	43	6	32		0	0	0	0	0	0	66.52	0	0	11.8
2015	7	12	17	53	6	32		0	0	0	0	0	0	66.51	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	12	18	3	6	33	0	0	0	0	0	0	0	66.49	0	0	11.6
2015	7	12	18	13	6	33	0	0	0	0	0	0	0	66.51	0	0	11.4
2015	7	12	18	23	6	33	0	0	0	0	0	0	0	66.51	0	0	11.2
2015	7	12	18	33	6	33	0	0	0	0	0	0	0	66.49	0	0	11.2
2015	7	12	18	43	6	33	0	0	0	0	0	0	0	66.51	0	0	11.2
2015	7	12	18	53	6	32	0	0	0	0	0	0	0	66.49	0	0	11
2015	7	12	19	3	6	32	0	0	0	0	0	0	0	66.49	0	0	11
2015	7	12	19	13	6	33	0	0	0	0	0	0	0	66.47	0	0	11
2015	7	12	19	23	6	33	0	0	0	0	0	0	0	66.47	0	0	11
2015	7	12	19	33	6	33	0	0	0	0	0	0	0	66.47	0	0	10.8
2015	7	12	19	43	6	33	0	0	0	0	0	0	0	66.47	0	0	10.8
2015	7	12	19	53	6	32	0	0	0	0	0	0	0	66.47	0	0	11
2015	7	12	20	3	6	33	0	0	0	0	0	0	0	66.47	0	0	11
2015	7	12	20	13	6	32	0	0	0	0	0	0	0	66.47	0	0	11
2015	7	12	20	23	6	32	0	0	0	0	0	0	0	66.45	0	0	11
2015	7	12	20	33	6	33	0	0	0	0	0	0	0	66.45	0	0	11.8
2015	7	12	20	43	6	33	0	0	0	0	0	0	0	66.45	0	0	11.8
2015	7	12	20	53	6	32	0	0	0	0	0	0	0	66.45	0	0	11.8
2015	7	12	21	3	6	33	0	0	0	0	0	0	0	66.43	0	0	11.8
2015	7	12	21	13	6	32	0	0	0	0	0	0	0	66.43	0	0	11.8
2015	7	12	21	23	6	33	0	0	0	0	0	0	0	66.42	0	0	11.8
2015	7	12	21	33	6	32	0	0	0	0	0	0	0	66.42	0	0	11.8
2015	7	12	21	43	6	32	0	0	0	0	0	0	0	66.4	0	0	11.8
2015	7	12	21	53	6	33	0	0	0	0	0	0	0	66.42	0	0	11.8
2015	7	12	22	3	6	33	0	0	0	0	0	0	0	66.38	0	0	11.8
2015	7	12	22	13	6	32	0	0	0	0	0	0	0	66.38	0	0	11.8
2015	7	12	22	23	6	32	0	0	0	0	0	0	0	66.36	0	0	11.8
2015	7	12	22	33	6	32	0	0	0	0	0	0	0	66.34	0	0	11.8
2015	7	12	22	43	6	32	0	0	0	0	0	0	0	66.33	0	0	11.8
2015	7	12	22	53	6	32	0	0	0	0	0	0	0	66.33	0	0	11.8
2015	7	12	23	3	6	32	0	0	0	0	0	0	0	66.29	0	0	11.8
2015	7	12	23	13	6	32	0	0	0	0	0	0	0	66.27	0	0	11.8
2015	7	12	23	23	6	33	0	0	0	0	0	0	0	66.27	0	0	11.8
2015	7	12	23	33	6	34	0	0	0	0	0	0	0	66.24	0	0	11.8
2015	7	12	23	43	6	32	0	0	0	0	0	0	0	66.22	0	0	11.8
2015	7	12	23	53	6	33	0	0	0	0	0	0	0	66.2	0	0	11.8
2015	7	13	0	3	6	32	0	0	0	0	0	0	0	66.18	0	0	11.8
2015	7	13	0	13	6	32	0	0	0	0	0	0	0	66.15	0	0	11.8
2015	7	13	0	23	6	32	0	0	0	0	0	0	0	66.15	0	0	11.8
2015	7	13	0	33	6	33	0	0	0	0	0	0	0	66.13	0	0	11.2
2015	7	13	0	43	6	32	0	0	0	0	0	0	0	66.11	0	0	11
2015	7	13	0	53	6	33	0	0	0	0	0	0	0	66.09	0	0	10.8
2015	7	13	1	3	6	33	0	0	0	0	0	0	0	66.07	0	0	10.8
2015	7	13	1	13	6	32	0	0	0	0	0	0	0	66.06	0	0	10.8
2015	7	13	1	23	6	32	0	0	0	0	0	0	0	66.04	0	0	10.8
2015	7	13	1	33	6	32	0	0	0	0	0	0	0	66.04	0	0	11
2015	7	13	1	43	6	32	0	0	0	0	0	0	0	66.02	0	0	11

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	13	1	53	6	33		0	0	0	0	0	0	66	0	0	11
2015	7	13	2	3	6	33		0	0	0	0	0	0	65.98	0	0	10.8
2015	7	13	2	13	6	33		0	0	0	0	0	0	65.97	0	0	10.8
2015	7	13	2	23	6	33		0	0	0	0	0	0	65.93	0	0	10.8
2015	7	13	2	33	6	32		0	0	0	0	0	0	65.91	0	0	11
2015	7	13	2	43	6	32		0	0	0	0	0	0	65.89	0	0	11
2015	7	13	2	53	6	32		0	0	0	0	0	0	65.86	0	0	11
2015	7	13	3	3	6	33		0	0	0	0	0	0	65.84	0	0	11
2015	7	13	3	13	6	33		0	0	0	0	0	0	65.8	0	0	11.8
2015	7	13	3	23	6	32		0	0	0	0	0	0	65.77	0	0	11.8
2015	7	13	3	33	6	33		0	0	0	0	0	0	65.73	0	0	11.8
2015	7	13	3	43	6	32		0	0	0	0	0	0	65.7	0	0	11.8
2015	7	13	3	53	6	33		0	0	0	0	0	0	65.66	0	0	11.8
2015	7	13	4	3	6	32		0	0	0	0	0	0	65.62	0	0	11.8
2015	7	13	4	13	6	32		0	0	0	0	0	0	65.59	0	0	11.8
2015	7	13	4	23	6	32		0	0	0	0	0	0	65.53	0	0	11.8
2015	7	13	4	33	6	32		0	0	0	0	0	0	65.52	0	0	11.8
2015	7	13	4	43	6	33		0	0	0	0	0	0	65.48	0	0	11.8
2015	7	13	4	53	6	32		0	0	0	0	0	0	65.43	0	0	11.8
2015	7	13	5	3	6	33		0	0	0	0	0	0	65.39	0	0	11.8
2015	7	13	5	13	6	32		0	0	0	0	0	0	65.34	0	0	11.8
2015	7	13	5	23	6	32		0	0	0	0	0	0	65.3	0	0	11.8
2015	7	13	5	33	6	33		0	0	0	0	0	0	65.26	0	0	11.8
2015	7	13	5	43	6	33		0	0	0	0	0	0	65.23	0	0	11.8
2015	7	13	5	53	6	33		0	0	0	0	0	0	65.17	0	0	11.8
2015	7	13	6	3	6	33		0	0	0	0	0	0	65.14	0	0	11.8
2015	7	13	6	13	6	33		0	0	0	0	0	0	65.1	0	0	11.8
2015	7	13	6	23	6	32		0	0	0	0	0	0	65.08	0	0	11.8
2015	7	13	6	33	6	32		0	0	0	0	0	0	65.07	0	0	11.8
2015	7	13	6	43	6	32		0	0	0	0	0	0	65.03	0	0	11.8
2015	7	13	6	53	6	33		0	0	0	0	0	0	65.01	0	0	11.8
2015	7	13	7	3	6	33		0	0	0	0	0	0	64.99	0	0	11.8
2015	7	13	7	13	6	33		0	0	0	0	0	0	64.99	0	0	12
2015	7	13	7	23	6	32		0	0	0	0	0	0	64.98	0	0	11.8
2015	7	13	7	33	6	33		0	0	0	0	0	0	64.98	0	0	11.6
2015	7	13	7	43	6	33		0	0	0	0	0	0	64.98	0	0	12.6
2015	7	13	7	53	6	33		0	0	0	0	0	0	64.98	0	0	12.6
2015	7	13	8	3	6	33		0	0	0	0	0	0	64.99	0	0	12.8
2015	7	13	8	13	6	32		0	0	0	0	0	0	64.99	0	0	12
2015	7	13	8	23	6	33		0	0	0	0	0	0	64.99	0	0	12.2
2015	7	13	8	33	6	34		0	0	0	0	0	0	64.99	0	0	12
2015	7	13	8	43	6	33		0	0	0	0	0	0	65.03	0	0	13
2015	7	13	8	53	6	33		0	0	0	0	0	0	65.03	0	0	12.8
2015	7	13	9	3	6	33		0	0	0	0	0	0	65.03	0	0	12.2
2015	7	13	9	13	6	33		0	0	0	0	0	0	65.07	0	0	12.8
2015	7	13	9	23	6	32		0	0	0	0	0	0	65.14	0	0	13.2
2015	7	13	9	33	6	32		0	0	0	0	0	0	65.14	0	0	12.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	13	9	43	6	33	0	0	0	0	0	0	0	65.23	0	0	13
2015	7	13	9	53	6	33	0	0	0	0	0	0	0	65.28	0	0	13
2015	7	13	10	3	6	33	0	0	0	0	0	0	0	65.32	0	0	13
2015	7	13	10	13	6	32	0	0	0	0	0	0	0	65.37	0	0	13
2015	7	13	10	23	6	33	0	0	0	0	0	0	0	65.43	0	0	13
2015	7	13	10	33	6	33	0	0	0	0	0	0	0	65.46	0	0	13
2015	7	13	10	43	6	33	0	0	0	0	0	0	0	65.5	0	0	13
2015	7	13	10	53	6	32	0	0	0	0	0	0	0	65.55	0	0	13.2
2015	7	13	11	3	6	33	0	0	0	0	0	0	0	65.61	0	0	13
2015	7	13	11	13	6	33	0	0	0	0	0	0	0	65.66	0	0	13
2015	7	13	11	23	6	33	0	0	0	0	0	0	0	65.7	0	0	13
2015	7	13	11	33	6	32	0	0	0	0	0	0	0	65.77	0	0	13.2
2015	7	13	11	43	6	32	0	0	0	0	0	0	0	65.82	0	0	13.2
2015	7	13	11	53	6	32	0	0	0	0	0	0	0	65.89	0	0	13.2
2015	7	13	12	3	6	33	0	0	0	0	0	0	0	65.95	0	0	13.2
2015	7	13	12	13	6	32	0	0	0	0	0	0	0	66.02	0	0	13.2
2015	7	13	12	23	6	33	0	0	0	0	0	0	0	66.09	0	0	13.2
2015	7	13	12	33	6	33	0	0	0	0	0	0	0	66.15	0	0	13.2
2015	7	13	12	43	6	33	0	0	0	0	0	0	0	66.2	0	0	13.2
2015	7	13	12	53	6	32	0	0	0	0	0	0	0	66.29	0	0	13.2
2015	7	13	13	3	6	33	0	0	0	0	0	0	0	66.36	0	0	13.2
2015	7	13	13	13	6	32	0	0	0	0	0	0	0	66.36	0	0	13
2015	7	13	13	23	6	32	0	0	0	0	0	0	0	66.47	0	0	13
2015	7	13	13	33	6	32	0	0	0	0	0	0	0	66.56	0	0	13
2015	7	13	13	43	6	32	0	0	0	0	0	0	0	66.61	0	0	13
2015	7	13	13	53	6	33	0	0	0	0	0	0	0	66.69	0	0	13
2015	7	13	14	3	6	33	0	0	0	0	0	0	0	66.76	0	0	13.2
2015	7	13	14	13	6	33	0	0	0	0	0	0	0	66.81	0	0	13.2
2015	7	13	14	23	6	32	0	0	0	0	0	0	0	66.88	0	0	13.2
2015	7	13	14	33	6	33	0	0	0	0	0	0	0	66.94	0	0	13.2
2015	7	13	14	43	6	32	0	0	0	0	0	0	0	66.99	0	0	13.2
2015	7	13	14	53	6	32	0	0	0	0	0	0	0	67.05	0	0	13.2
2015	7	13	15	3	6	33	0	0	0	0	0	0	0	67.12	0	0	13
2015	7	13	15	13	6	32	0	0	0	0	0	0	0	67.15	0	0	13
2015	7	13	15	23	6	32	0	0	0	0	0	0	0	67.17	0	0	13
2015	7	13	15	33	6	33	0	0	0	0	0	0	0	67.23	0	0	13
2015	7	13	15	43	6	33	0	0	0	0	0	0	0	67.24	0	0	13
2015	7	13	15	53	6	33	0	0	0	0	0	0	0	67.28	0	0	13
2015	7	13	16	3	6	32	0	0	0	0	0	0	0	67.3	0	0	12.8
2015	7	13	16	13	6	33	0	0	0	0	0	0	0	67.32	0	0	12.8
2015	7	13	16	23	6	32	0	0	0	0	0	0	0	67.33	0	0	12.8
2015	7	13	16	33	6	33	0	0	0	0	0	0	0	67.35	0	0	12.8
2015	7	13	16	43	6	32	0	0	0	0	0	0	0	67.37	0	0	12.6
2015	7	13	16	53	6	32	0	0	0	0	0	0	0	67.39	0	0	12.6
2015	7	13	17	3	6	32	0	0	0	0	0	0	0	67.39	0	0	12.6
2015	7	13	17	13	6	33	0	0	0	0	0	0	0	67.41	0	0	12.4
2015	7	13	17	23	6	33	0	0	0	0	0	0	0	67.39	0	0	12.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	13	17	33	6	32	0	0	0	0	0	0	0	67.39	0	0	12.2
2015	7	13	17	43	6	33	0	0	0	0	0	0	0	67.41	0	0	12
2015	7	13	17	53	6	33	0	0	0	0	0	0	0	67.41	0	0	12
2015	7	13	18	3	6	33	0	0	0	0	0	0	0	67.41	0	0	11.6
2015	7	13	18	13	6	33	0	0	0	0	0	0	0	67.41	0	0	11.4
2015	7	13	18	23	6	33	0	0	0	0	0	0	0	67.41	0	0	11.2
2015	7	13	18	33	6	33	0	0	0	0	0	0	0	67.39	0	0	10.8
2015	7	13	18	43	6	32	0	0	0	0	0	0	0	67.41	0	0	10.8
2015	7	13	18	53	6	32	0	0	0	0	0	0	0	67.41	0	0	10.8
2015	7	13	19	3	6	32	0	0	0	0	0	0	0	67.41	0	0	10.8
2015	7	13	19	13	6	33	0	0	0	0	0	0	0	67.41	0	0	10.8
2015	7	13	19	23	6	32	0	0	0	0	0	0	0	67.41	0	0	10.6
2015	7	13	19	33	6	32	0	0	0	0	0	0	0	67.41	0	0	10.8
2015	7	13	19	43	6	32	0	0	0	0	0	0	0	67.41	0	0	10.8
2015	7	13	19	53	6	32	0	0	0	0	0	0	0	67.41	0	0	10.6
2015	7	13	20	3	6	32	0	0	0	0	0	0	0	67.41	0	0	10.6
2015	7	13	20	13	6	32	0	0	0	0	0	0	0	67.39	0	0	10.6
2015	7	13	20	23	6	33	0	0	0	0	0	0	0	67.39	0	0	10.6
2015	7	13	20	33	6	32	0	0	0	0	0	0	0	67.37	0	0	11.8
2015	7	13	20	43	6	32	0	0	0	0	0	0	0	67.35	0	0	11.8
2015	7	13	20	53	6	32	0	0	0	0	0	0	0	67.35	0	0	11.8
2015	7	13	21	3	6	32	0	0	0	0	0	0	0	67.35	0	0	11.8
2015	7	13	21	13	6	32	0	0	0	0	0	0	0	67.33	0	0	11.8
2015	7	13	21	23	6	32	0	0	0	0	0	0	0	67.32	0	0	11.8
2015	7	13	21	33	6	33	0	0	0	0	0	0	0	67.32	0	0	11.8
2015	7	13	21	43	6	32	0	0	0	0	0	0	0	67.3	0	0	11.8
2015	7	13	21	53	6	32	0	0	0	0	0	0	0	67.28	0	0	11.8
2015	7	13	22	3	6	32	0	0	0	0	0	0	0	67.26	0	0	11.8
2015	7	13	22	13	6	32	0	0	0	0	0	0	0	67.24	0	0	11.8
2015	7	13	22	23	6	33	0	0	0	0	0	0	0	67.23	0	0	11.8
2015	7	13	22	33	6	33	0	0	0	0	0	0	0	67.21	0	0	11.8
2015	7	13	22	43	6	32	0	0	0	0	0	0	0	67.19	0	0	11.8
2015	7	13	22	53	6	32	0	0	0	0	0	0	0	67.17	0	0	11.8
2015	7	13	23	3	6	33	0	0	0	0	0	0	0	67.15	0	0	11.8
2015	7	13	23	13	6	32	0	0	0	0	0	0	0	67.14	0	0	11.8
2015	7	13	23	23	6	33	0	0	0	0	0	0	0	67.1	0	0	11.8
2015	7	13	23	33	6	33	0	0	0	0	0	0	0	67.1	0	0	11.8
2015	7	13	23	43	6	33	0	0	0	0	0	0	0	67.08	0	0	11.8
2015	7	13	23	53	6	32	0	0	0	0	0	0	0	67.06	0	0	11.8
2015	7	14	0	3	6	33	0	0	0	0	0	0	0	67.05	0	0	11.8
2015	7	14	0	13	6	32	0	0	0	0	0	0	0	67.03	0	0	11.8
2015	7	14	0	23	6	32	0	0	0	0	0	0	0	67.01	0	0	11.8
2015	7	14	0	33	6	33	0	0	0	0	0	0	0	67.01	0	0	11
2015	7	14	0	43	6	33	0	0	0	0	0	0	0	66.99	0	0	11
2015	7	14	0	53	6	32	0	0	0	0	0	0	0	66.97	0	0	11
2015	7	14	1	3	6	32	0	0	0	0	0	0	0	66.96	0	0	11
2015	7	14	1	13	6	32	0	0	0	0	0	0	0	66.96	0	0	11

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	14	1	23	6	33	0	0	0	0	0	0	0	66.94	0	0	11
2015	7	14	1	33	6	32	0	0	0	0	0	0	0	66.92	0	0	11.8
2015	7	14	1	43	6	33	0	0	0	0	0	0	0	66.9	0	0	11.8
2015	7	14	1	53	6	32	0	0	0	0	0	0	0	66.88	0	0	11.8
2015	7	14	2	3	6	33	0	0	0	0	0	0	0	66.85	0	0	11.8
2015	7	14	2	13	6	32	0	0	0	0	0	0	0	66.83	0	0	11.8
2015	7	14	2	23	6	32	0	0	0	0	0	0	0	66.81	0	0	11.8
2015	7	14	2	33	6	32	0	0	0	0	0	0	0	66.78	0	0	11.8
2015	7	14	2	43	6	33	0	0	0	0	0	0	0	66.74	0	0	11.8
2015	7	14	2	53	6	32	0	0	0	0	0	0	0	66.7	0	0	11.8
2015	7	14	3	3	6	32	0	0	0	0	0	0	0	66.69	0	0	11.6
2015	7	14	3	13	6	33	0	0	0	0	0	0	0	66.65	0	0	11.6
2015	7	14	3	23	6	33	0	0	0	0	0	0	0	66.6	0	0	11.6
2015	7	14	3	33	6	32	0	0	0	0	0	0	0	66.58	0	0	11.8
2015	7	14	3	43	6	32	0	0	0	0	0	0	0	66.54	0	0	11.8
2015	7	14	3	53	6	33	0	0	0	0	0	0	0	66.49	0	0	11.8
2015	7	14	4	3	6	32	0	0	0	0	0	0	0	66.45	0	0	11.8
2015	7	14	4	13	6	32	0	0	0	0	0	0	0	66.4	0	0	11.8
2015	7	14	4	23	6	33	0	0	0	0	0	0	0	66.36	0	0	11.8
2015	7	14	4	33	6	32	0	0	0	0	0	0	0	66.33	0	0	11.8
2015	7	14	4	43	6	33	0	0	0	0	0	0	0	66.27	0	0	11.6
2015	7	14	4	53	6	33	0	0	0	0	0	0	0	66.24	0	0	11.6
2015	7	14	5	3	6	33	0	0	0	0	0	0	0	66.18	0	0	11.6
2015	7	14	5	13	6	32	0	0	0	0	0	0	0	66.15	0	0	11.6
2015	7	14	5	23	6	32	0	0	0	0	0	0	0	66.09	0	0	11.6
2015	7	14	5	33	6	32	0	0	0	0	0	0	0	66.06	0	0	11.6
2015	7	14	5	43	6	33	0	0	0	0	0	0	0	66	0	0	11.6
2015	7	14	5	53	6	32	0	0	0	0	0	0	0	65.97	0	0	11.6
2015	7	14	6	3	6	33	0	0	0	0	0	0	0	65.93	0	0	11.6
2015	7	14	6	13	6	32	0	0	0	0	0	0	0	65.88	0	0	11.6
2015	7	14	6	23	6	33	0	0	0	0	0	0	0	65.82	0	0	11.6
2015	7	14	6	33	6	33	0	0	0	0	0	0	0	65.79	0	0	11.6
2015	7	14	6	43	6	32	0	0	0	0	0	0	0	65.75	0	0	11.6
2015	7	14	6	53	6	32	0	0	0	0	0	0	0	65.71	0	0	11.8
2015	7	14	7	3	6	33	0	0	0	0	0	0	0	65.68	0	0	11.8
2015	7	14	7	13	6	33	0	0	0	0	0	0	0	65.64	0	0	11.8
2015	7	14	7	23	6	33	0	0	0	0	0	0	0	65.64	0	0	11.8
2015	7	14	7	33	6	32	0	0	0	0	0	0	0	65.62	0	0	12
2015	7	14	7	43	6	32	0	0	0	0	0	0	0	65.61	0	0	12
2015	7	14	7	53	6	32	0	0	0	0	0	0	0	65.61	0	0	12
2015	7	14	8	3	6	33	0	0	0	0	0	0	0	65.59	0	0	12.2
2015	7	14	8	13	6	33	0	0	0	0	0	0	0	65.61	0	0	12.2
2015	7	14	8	23	6	33	0	0	0	0	0	0	0	65.61	0	0	12.2
2015	7	14	8	33	6	33	0	0	0	0	0	0	0	65.61	0	0	12.2
2015	7	14	8	43	6	32	0	0	0	0	0	0	0	65.62	0	0	12.2
2015	7	14	8	53	6	32	0	0	0	0	0	0	0	65.64	0	0	12.2
2015	7	14	9	3	6	33	0	0	0	0	0	0	0	65.68	0	0	12.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	14	9	13	6	33	0	0	0	0	0	0	0	65.7	0	0	12.4
2015	7	14	9	23	6	33	0	0	0	0	0	0	0	65.75	0	0	12.4
2015	7	14	9	33	6	33	0	0	0	0	0	0	0	65.77	0	0	12.4
2015	7	14	9	43	6	33	0	0	0	0	0	0	0	65.82	0	0	12.4
2015	7	14	9	53	6	33	0	0	0	0	0	0	0	65.86	0	0	12.8
2015	7	14	10	3	6	33	0	0	0	0	0	0	0	65.89	0	0	13
2015	7	14	10	13	6	32	0	0	0	0	0	0	0	65.95	0	0	13.2
2015	7	14	10	23	6	32	0	0	0	0	0	0	0	66	0	0	13
2015	7	14	10	33	6	32	0	0	0	0	0	0	0	66.04	0	0	13
2015	7	14	10	43	6	32	0	0	0	0	0	0	0	66.11	0	0	13
2015	7	14	10	53	6	32	0	0	0	0	0	0	0	66.16	0	0	12.8
2015	7	14	11	3	6	33	0	0	0	0	0	0	0	66.22	0	0	13
2015	7	14	11	13	6	33	0	0	0	0	0	0	0	66.27	0	0	12.8
2015	7	14	11	23	6	33	0	0	0	0	0	0	0	66.34	0	0	12.8
2015	7	14	11	33	6	32	0	0	0	0	0	0	0	66.4	0	0	13
2015	7	14	11	43	6	32	0	0	0	0	0	0	0	66.47	0	0	13.8
2015	7	14	11	53	6	33	0	0	0	0	0	0	0	66.52	0	0	13.8
2015	7	14	12	3	6	32	0	0	0	0	0	0	0	66.6	0	0	13.6
2015	7	14	12	13	6	33	0	0	0	0	0	0	0	66.67	0	0	13.8
2015	7	14	12	23	6	33	0	0	0	0	0	0	0	66.72	0	0	13.8
2015	7	14	12	33	6	33	0	0	0	0	0	0	0	66.79	0	0	13.8
2015	7	14	12	43	6	32	0	0	0	0	0	0	0	66.87	0	0	13.8
2015	7	14	12	53	6	32	0	0	0	0	0	0	0	66.92	0	0	13.8
2015	7	14	13	3	6	32	0	0	0	0	0	0	0	67.01	0	0	13.8
2015	7	14	13	13	6	33	0	0	0	0	0	0	0	67.06	0	0	13.8
2015	7	14	13	23	6	33	0	0	0	0	0	0	0	67.12	0	0	13.8
2015	7	14	13	33	6	32	0	0	0	0	0	0	0	67.19	0	0	13.8
2015	7	14	13	43	6	33	0	0	0	0	0	0	0	67.26	0	0	13.8
2015	7	14	13	53	6	33	0	0	0	0	0	0	0	67.33	0	0	13.8
2015	7	14	14	3	6	32	0	0	0	0	0	0	0	67.39	0	0	13.4
2015	7	14	14	13	6	32	0	0	0	0	0	0	0	67.44	0	0	13.2
2015	7	14	14	23	6	33	0	0	0	0	0	0	0	67.5	0	0	13.2
2015	7	14	14	33	6	33	0	0	0	0	0	0	0	67.55	0	0	13
2015	7	14	14	43	6	32	0	0	0	0	0	0	0	67.62	0	0	13
2015	7	14	14	53	6	32	0	0	0	0	0	0	0	67.64	0	0	13
2015	7	14	15	3	6	33	0	0	0	0	0	0	0	67.69	0	0	13
2015	7	14	15	13	6	32	0	0	0	0	0	0	0	67.75	0	0	13
2015	7	14	15	23	6	31	0	0	0	0	0	0	0	67.78	0	0	13
2015	7	14	15	33	6	32	0	0	0	0	0	0	0	67.82	0	0	13
2015	7	14	15	43	6	32	0	0	0	0	0	0	0	67.86	0	0	13
2015	7	14	15	53	6	33	0	0	0	0	0	0	0	67.89	0	0	13
2015	7	14	16	3	6	32	0	0	0	0	0	0	0	67.91	0	0	12.8
2015	7	14	16	13	6	32	0	0	0	0	0	0	0	67.93	0	0	12.8
2015	7	14	16	23	6	32	0	0	0	0	0	0	0	67.96	0	0	12.8
2015	7	14	16	33	6	33	0	0	0	0	0	0	0	67.96	0	0	12.8
2015	7	14	16	43	6	32	0	0	0	0	0	0	0	67.98	0	0	12.6
2015	7	14	16	53	6	33	0	0	0	0	0	0	0	67.98	0	0	12.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	14	17	3	6	32	0	0	0	0	0	0	0	68	0	0	12.4
2015	7	14	17	13	6	32	0	0	0	0	0	0	0	68	0	0	12.4
2015	7	14	17	23	6	32	0	0	0	0	0	0	0	68	0	0	12.2
2015	7	14	17	33	6	32	0	0	0	0	0	0	0	68	0	0	12.2
2015	7	14	17	43	6	32	0	0	0	0	0	0	0	68	0	0	11.8
2015	7	14	17	53	6	32	0	0	0	0	0	0	0	68	0	0	11.8
2015	7	14	18	3	6	33	0	0	0	0	0	0	0	68	0	0	11.6
2015	7	14	18	13	6	32	0	0	0	0	0	0	0	68	0	0	11.4
2015	7	14	18	23	6	33	0	0	0	0	0	0	0	68	0	0	11.4
2015	7	14	18	33	6	32	0	0	0	0	0	0	0	68.02	0	0	11.2
2015	7	14	18	43	6	33	0	0	0	0	0	0	0	68.02	0	0	11
2015	7	14	18	53	6	32	0	0	0	0	0	0	0	68.02	0	0	10.6
2015	7	14	19	3	6	32	0	0	0	0	0	0	0	68.02	0	0	10.6
2015	7	14	19	13	6	33	0	0	0	0	0	0	0	68.02	0	0	10.6
2015	7	14	19	23	6	32	0	0	0	0	0	0	0	68.02	0	0	10.4
2015	7	14	19	33	6	32	0	0	0	0	0	0	0	68.02	0	0	10.6
2015	7	14	19	43	6	32	0	0	0	0	0	0	0	68.02	0	0	10.4
2015	7	14	19	53	6	33	0	0	0	0	0	0	0	68.02	0	0	10.4
2015	7	14	20	3	6	32	0	0	0	0	0	0	0	68.02	0	0	10.4
2015	7	14	20	13	6	33	0	0	0	0	0	0	0	68	0	0	10.2
2015	7	14	20	23	6	32	0	0	0	0	0	0	0	68	0	0	10.2
2015	7	14	20	33	6	33	0	0	0	0	0	0	0	68	0	0	10.4
2015	7	14	20	43	6	32	0	0	0	0	0	0	0	68	0	0	10.2
2015	7	14	20	53	6	32	0	0	0	0	0	0	0	68	0	0	10.2
2015	7	14	21	3	6	33	0	0	0	0	0	0	0	67.98	0	0	10
2015	7	14	21	13	6	32	0	0	0	0	0	0	0	67.96	0	0	10
2015	7	14	21	23	6	32	0	0	0	0	0	0	0	67.95	0	0	10
2015	7	14	21	33	6	33	0	0	0	0	0	0	0	67.93	0	0	10.4
2015	7	14	21	43	6	32	0	0	0	0	0	0	0	67.93	0	0	10.4
2015	7	14	21	53	6	32	0	0	0	0	0	0	0	67.93	0	0	10.2
2015	7	14	22	3	6	32	0	0	0	0	0	0	0	67.91	0	0	10.2
2015	7	14	22	13	6	33	0	0	0	0	0	0	0	67.89	0	0	10.2
2015	7	14	22	23	6	33	0	0	0	0	0	0	0	67.87	0	0	10.2
2015	7	14	22	33	6	32	0	0	0	0	0	0	0	67.86	0	0	10.8
2015	7	14	22	43	6	33	0	0	0	0	0	0	0	67.84	0	0	10.8
2015	7	14	22	53	6	32	0	0	0	0	0	0	0	67.8	0	0	10.6
2015	7	14	23	3	6	32	0	0	0	0	0	0	0	67.8	0	0	10.6
2015	7	14	23	13	6	33	0	0	0	0	0	0	0	67.77	0	0	10.6
2015	7	14	23	23	6	32	0	0	0	0	0	0	0	67.75	0	0	10.6
2015	7	14	23	33	6	33	0	0	0	0	0	0	0	67.75	0	0	10.8
2015	7	14	23	43	6	32	0	0	0	0	0	0	0	67.73	0	0	10.6
2015	7	14	23	53	6	32	0	0	0	0	0	0	0	67.71	0	0	10.6
2015	7	15	0	3	6	32	0	0	0	0	0	0	0	67.69	0	0	10.6
2015	7	15	0	13	6	32	0	0	0	0	0	0	0	67.68	0	0	10.6
2015	7	15	0	23	6	32	0	0	0	0	0	0	0	67.68	0	0	10.4
2015	7	15	0	33	6	32	0	0	0	0	0	0	0	67.66	0	0	11.8
2015	7	15	0	43	6	32	0	0	0	0	0	0	0	67.64	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	15	0	53	6	32		0	0	0	0	0	0	67.62	0	0	11.8
2015	7	15	1	3	6	33		0	0	0	0	0	0	67.62	0	0	11.8
2015	7	15	1	13	6	33		0	0	0	0	0	0	67.6	0	0	11.8
2015	7	15	1	23	6	32		0	0	0	0	0	0	67.59	0	0	11.8
2015	7	15	1	33	6	32		0	0	0	0	0	0	67.59	0	0	11.8
2015	7	15	1	43	6	33		0	0	0	0	0	0	67.57	0	0	11.8
2015	7	15	1	53	6	33		0	0	0	0	0	0	67.55	0	0	11.8
2015	7	15	2	3	6	32		0	0	0	0	0	0	67.53	0	0	11.8
2015	7	15	2	13	6	32		0	0	0	0	0	0	67.5	0	0	11.8
2015	7	15	2	23	6	32		0	0	0	0	0	0	67.48	0	0	11.8
2015	7	15	2	33	6	32		0	0	0	0	0	0	67.46	0	0	11.8
2015	7	15	2	43	6	33		0	0	0	0	0	0	67.42	0	0	11.8
2015	7	15	2	53	6	33		0	0	0	0	0	0	67.41	0	0	11.8
2015	7	15	3	3	6	33		0	0	0	0	0	0	67.37	0	0	11.8
2015	7	15	3	13	6	32		0	0	0	0	0	0	67.33	0	0	11.8
2015	7	15	3	23	6	32		0	0	0	0	0	0	67.32	0	0	11.8
2015	7	15	3	33	6	33		0	0	0	0	0	0	67.26	0	0	11.8
2015	7	15	3	43	6	31		0	0	0	0	0	0	67.23	0	0	11.8
2015	7	15	3	53	6	31		0	0	0	0	0	0	67.17	0	0	11.6
2015	7	15	4	3	6	33		0	0	0	0	0	0	67.14	0	0	11.6
2015	7	15	4	13	6	32		0	0	0	0	0	0	67.08	0	0	11.6
2015	7	15	4	23	6	33		0	0	0	0	0	0	67.05	0	0	11.6
2015	7	15	4	33	6	32		0	0	0	0	0	0	66.99	0	0	11.6
2015	7	15	4	43	6	33		0	0	0	0	0	0	66.96	0	0	11.6
2015	7	15	4	53	6	33		0	0	0	0	0	0	66.92	0	0	11.6
2015	7	15	5	3	6	33		0	0	0	0	0	0	66.87	0	0	11.6
2015	7	15	5	13	6	32		0	0	0	0	0	0	66.83	0	0	11.6
2015	7	15	5	23	6	32		0	0	0	0	0	0	66.78	0	0	11.6
2015	7	15	5	33	6	32		0	0	0	0	0	0	66.72	0	0	11.6
2015	7	15	5	43	6	31		0	0	0	0	0	0	66.67	0	0	11.6
2015	7	15	5	53	6	33		0	0	0	0	0	0	66.61	0	0	11.6
2015	7	15	6	3	6	32		0	0	0	0	0	0	66.58	0	0	11.6
2015	7	15	6	13	6	33		0	0	0	0	0	0	66.52	0	0	11.6
2015	7	15	6	23	6	33		0	0	0	0	0	0	66.47	0	0	11.6
2015	7	15	6	33	6	33		0	0	0	0	0	0	66.43	0	0	11.6
2015	7	15	6	43	6	32		0	0	0	0	0	0	66.38	0	0	11.6
2015	7	15	6	53	6	32		0	0	0	0	0	0	66.34	0	0	11.8
2015	7	15	7	3	6	32		0	0	0	0	0	0	66.31	0	0	11.8
2015	7	15	7	13	6	33		0	0	0	0	0	0	66.27	0	0	11.8
2015	7	15	7	23	6	33		0	0	0	0	0	0	66.25	0	0	11.8
2015	7	15	7	33	6	33		0	0	0	0	0	0	66.22	0	0	12
2015	7	15	7	43	6	32		0	0	0	0	0	0	66.2	0	0	12
2015	7	15	7	53	6	32		0	0	0	0	0	0	66.18	0	0	12
2015	7	15	8	3	6	32		0	0	0	0	0	0	66.16	0	0	12.2
2015	7	15	8	13	6	32		0	0	0	0	0	0	66.16	0	0	12.2
2015	7	15	8	23	6	33		0	0	0	0	0	0	66.16	0	0	12.4
2015	7	15	8	33	6	33		0	0	0	0	0	0	66.16	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	15	8	43	6	33		0	0	0	0	0	0	66.16	0	0	13
2015	7	15	8	53	6	32		0	0	0	0	0	0	66.18	0	0	13
2015	7	15	9	3	6	32		0	0	0	0	0	0	66.2	0	0	13
2015	7	15	9	13	6	33		0	0	0	0	0	0	66.22	0	0	13
2015	7	15	9	23	6	33		0	0	0	0	0	0	66.24	0	0	13
2015	7	15	9	33	6	32		0	0	0	0	0	0	66.27	0	0	13
2015	7	15	9	43	6	32		0	0	0	0	0	0	66.31	0	0	13
2015	7	15	9	53	6	32		0	0	0	0	0	0	66.33	0	0	13
2015	7	15	10	3	6	32		0	0	0	0	0	0	66.38	0	0	13
2015	7	15	10	13	6	32		0	0	0	0	0	0	66.43	0	0	13
2015	7	15	10	23	6	33		0	0	0	0	0	0	66.47	0	0	13
2015	7	15	10	33	6	33		0	0	0	0	0	0	66.51	0	0	13
2015	7	15	10	43	6	33		0	0	0	0	0	0	66.56	0	0	13
2015	7	15	10	53	6	32		0	0	0	0	0	0	66.61	0	0	12.8
2015	7	15	11	3	6	32		0	0	0	0	0	0	66.67	0	0	12.8
2015	7	15	11	13	6	32		0	0	0	0	0	0	66.72	0	0	13
2015	7	15	11	23	6	33		0	0	0	0	0	0	66.78	0	0	13
2015	7	15	11	33	6	32		0	0	0	0	0	0	66.85	0	0	13
2015	7	15	11	43	6	33		0	0	0	0	0	0	66.9	0	0	13
2015	7	15	11	53	6	32		0	0	0	0	0	0	66.94	0	0	13
2015	7	15	12	3	6	32		0	0	0	0	0	0	67.01	0	0	13
2015	7	15	12	13	6	33		0	0	0	0	0	0	67.06	0	0	12.8
2015	7	15	12	23	6	33		0	0	0	0	0	0	67.14	0	0	13
2015	7	15	12	33	6	32		0	0	0	0	0	0	67.19	0	0	13.2
2015	7	15	12	43	6	33		0	0	0	0	0	0	67.26	0	0	13.2
2015	7	15	12	53	6	32		0	0	0	0	0	0	67.33	0	0	13.2
2015	7	15	13	3	6	33		0	0	0	0	0	0	67.41	0	0	13
2015	7	15	13	13	6	33		0	0	0	0	0	0	67.46	0	0	13
2015	7	15	13	23	6	33		0	0	0	0	0	0	67.53	0	0	13
2015	7	15	13	33	6	32		0	0	0	0	0	0	67.59	0	0	13.4
2015	7	15	13	43	6	32		0	0	0	0	0	0	67.66	0	0	13.2
2015	7	15	13	53	6	33		0	0	0	0	0	0	67.73	0	0	13
2015	7	15	14	3	6	32		0	0	0	0	0	0	67.78	0	0	13
2015	7	15	14	13	6	33		0	0	0	0	0	0	67.84	0	0	13
2015	7	15	14	23	6	33		0	0	0	0	0	0	67.89	0	0	13
2015	7	15	14	33	6	33		0	0	0	0	0	0	67.93	0	0	13.2
2015	7	15	14	43	6	33		0	0	0	0	0	0	68	0	0	13
2015	7	15	14	53	6	32		0	0	0	0	0	0	68.04	0	0	13
2015	7	15	15	3	6	32		0	0	0	0	0	0	68.09	0	0	13
2015	7	15	15	13	6	33		0	0	0	0	0	0	68.13	0	0	13
2015	7	15	15	23	6	32		0	0	0	0	0	0	68.13	0	0	13
2015	7	15	15	33	6	32		0	0	0	0	0	0	68.18	0	0	13
2015	7	15	15	43	6	32		0	0	0	0	0	0	68.2	0	0	13
2015	7	15	15	53	6	33		0	0	0	0	0	0	68.22	0	0	13
2015	7	15	16	3	6	32		0	0	0	0	0	0	68.25	0	0	13
2015	7	15	16	13	6	33		0	0	0	0	0	0	68.25	0	0	12.8
2015	7	15	16	23	6	32		0	0	0	0	0	0	68.27	0	0	12.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	15	16	33	6	33		0	0	0	0	0	0	68.29	0	0	12.8
2015	7	15	16	43	6	33		0	0	0	0	0	0	68.29	0	0	12.6
2015	7	15	16	53	6	32		0	0	0	0	0	0	68.31	0	0	12.6
2015	7	15	17	3	6	33		0	0	0	0	0	0	68.31	0	0	12.4
2015	7	15	17	13	6	32		0	0	0	0	0	0	68.31	0	0	12.4
2015	7	15	17	23	6	33		0	0	0	0	0	0	68.31	0	0	12.4
2015	7	15	17	33	6	32		0	0	0	0	0	0	68.31	0	0	12.2
2015	7	15	17	43	6	32		0	0	0	0	0	0	68.31	0	0	11.8
2015	7	15	17	53	6	33		0	0	0	0	0	0	68.29	0	0	11.8
2015	7	15	18	3	6	32		0	0	0	0	0	0	68.29	0	0	11.4
2015	7	15	18	13	6	32		0	0	0	0	0	0	68.29	0	0	11.2
2015	7	15	18	23	6	33		0	0	0	0	0	0	68.29	0	0	11
2015	7	15	18	33	6	32		0	0	0	0	0	0	68.29	0	0	10.8
2015	7	15	18	43	6	32		0	0	0	0	0	0	68.31	0	0	10.6
2015	7	15	18	53	6	32		0	0	0	0	0	0	68.31	0	0	10.4
2015	7	15	19	3	6	32		0	0	0	0	0	0	68.29	0	0	10.4
2015	7	15	19	13	6	32		0	0	0	0	0	0	68.31	0	0	10.4
2015	7	15	19	23	6	33		0	0	0	0	0	0	68.29	0	0	10.4
2015	7	15	19	33	6	32		0	0	0	0	0	0	68.29	0	0	10.6
2015	7	15	19	43	6	33		0	0	0	0	0	0	68.29	0	0	10.4
2015	7	15	19	53	6	33		0	0	0	0	0	0	68.29	0	0	10.2
2015	7	15	20	3	6	33		0	0	0	0	0	0	68.29	0	0	10
2015	7	15	20	13	6	33		0	0	0	0	0	0	68.29	0	0	9.6
2015	7	15	20	23	6	32		0	0	0	0	0	0	68.29	0	0	9.6
2015	7	15	20	33	6	33		0	0	0	0	0	0	68.27	0	0	10.6
2015	7	15	20	43	6	32		0	0	0	0	0	0	68.27	0	0	10.6
2015	7	15	20	53	6	32		0	0	0	0	0	0	68.25	0	0	10.6
2015	7	15	21	3	6	32		0	0	0	0	0	0	68.25	0	0	10.4
2015	7	15	21	13	24	32		0	0	0	0	0	0	68.25	0	0	11.6
2015	7	15	21	23	24	31		0	0	0	0	0	0	68.23	0	0	11.4
2015	7	15	21	33	24	32		0	0	0	0	0	0	68.23	0	0	11.4
2015	7	15	21	43	24	32		0	0	0	0	0	0	68.22	0	0	11.4
2015	7	15	21	53	24	31		0	0	0	0	0	0	68.22	0	0	11.4
2015	7	15	22	3	24	33		0	0	0	0	0	0	68.22	0	0	11.4
2015	7	15	22	13	24	33		0	0	0	0	0	0	68.2	0	0	11.4
2015	7	15	22	23	24	33		0	0	0	0	0	0	68.2	0	0	11.4
2015	7	15	22	33	24	32		0	0	0	0	0	0	68.18	0	0	11.4
2015	7	15	22	43	24	32		0	0	0	0	0	0	68.18	0	0	11.4
2015	7	15	22	53	24	32		0	0	0	0	0	0	68.16	0	0	11.4
2015	7	15	23	3	24	32		0	0	0	0	0	0	68.14	0	0	11.4
2015	7	15	23	13	24	33		0	0	0	0	0	0	68.14	0	0	11.4
2015	7	15	23	23	24	33		0	0	0	0	0	0	68.13	0	0	11.4
2015	7	15	23	33	24	32		0	0	0	0	0	0	68.11	0	0	11.2
2015	7	15	23	43	24	33		0	0	0	0	0	0	68.09	0	0	11.2
2015	7	15	23	53	24	32		0	0	0	0	0	0	68.09	0	0	11.2
2015	7	16	0	3	24	32		0	0	0	0	0	0	68.05	0	0	11.2
2015	7	16	0	13	24	32		0	0	0	0	0	0	68.05	0	0	11.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	16	0	23	24	33		0	0	0	0	0	0	68.05	0	0	11.2
2015	7	16	0	33	24	33		0	0	0	0	0	0	68.04	0	0	11.2
2015	7	16	0	43	24	32		0	0	0	0	0	0	68.02	0	0	11.2
2015	7	16	0	53	24	32		0	0	0	0	0	0	68	0	0	11.2
2015	7	16	1	3	24	32		0	0	0	0	0	0	67.98	0	0	11.2
2015	7	16	1	13	24	32		0	0	0	0	0	0	67.95	0	0	11.2
2015	7	16	1	23	24	32		0	0	0	0	0	0	67.93	0	0	11.2
2015	7	16	1	33	24	33		0	0	0	0	0	0	67.91	0	0	11.2
2015	7	16	1	43	24	32		0	0	0	0	0	0	67.89	0	0	11.2
2015	7	16	1	53	24	32		0	0	0	0	0	0	67.87	0	0	11.2
2015	7	16	2	3	24	32		0	0	0	0	0	0	67.84	0	0	11.2
2015	7	16	2	13	24	33		0	0	0	0	0	0	67.82	0	0	11.2
2015	7	16	2	23	24	32		0	0	0	0	0	0	67.8	0	0	11.2
2015	7	16	2	33	24	33		0	0	0	0	0	0	67.77	0	0	11.2
2015	7	16	2	43	24	32		0	0	0	0	0	0	67.75	0	0	11.2
2015	7	16	2	53	24	33		0	0	0	0	0	0	67.71	0	0	11.2
2015	7	16	3	3	24	32		0	0	0	0	0	0	67.68	0	0	11.2
2015	7	16	3	13	24	33		0	0	0	0	0	0	67.64	0	0	11.2
2015	7	16	3	23	24	32		0	0	0	0	0	0	67.6	0	0	11.2
2015	7	16	3	33	24	33		0	0	0	0	0	0	67.59	0	0	11.2
2015	7	16	3	43	24	32		0	0	0	0	0	0	67.53	0	0	11.2
2015	7	16	3	53	24	32		0	0	0	0	0	0	67.5	0	0	11.2
2015	7	16	4	3	24	32		0	0	0	0	0	0	67.46	0	0	11.2
2015	7	16	4	13	24	32		0	0	0	0	0	0	67.41	0	0	11.2
2015	7	16	4	23	24	32		0	0	0	0	0	0	67.37	0	0	11.2
2015	7	16	4	33	24	32		0	0	0	0	0	0	67.33	0	0	11.2
2015	7	16	4	43	24	32		0	0	0	0	0	0	67.3	0	0	11.2
2015	7	16	4	53	24	32		0	0	0	0	0	0	67.26	0	0	11
2015	7	16	5	3	24	33		0	0	0	0	0	0	67.21	0	0	11
2015	7	16	5	13	24	33		0	0	0	0	0	0	67.15	0	0	11
2015	7	16	5	23	24	32		0	0	0	0	0	0	67.12	0	0	11
2015	7	16	5	33	24	32		0	0	0	0	0	0	67.06	0	0	11.2
2015	7	16	5	43	24	33		0	0	0	0	0	0	67.01	0	0	11.2
2015	7	16	5	53	24	32		0	0	0	0	0	0	66.97	0	0	11.2
2015	7	16	6	3	24	33		0	0	0	0	0	0	66.92	0	0	11.2
2015	7	16	6	13	24	33		0	0	0	0	0	0	66.87	0	0	11.2
2015	7	16	6	23	24	32		0	0	0	0	0	0	66.81	0	0	11.2
2015	7	16	6	33	24	33		0	0	0	0	0	0	66.76	0	0	11.2
2015	7	16	6	43	24	32		0	0	0	0	0	0	66.7	0	0	11.2
2015	7	16	6	53	24	34		0	0	0	0	0	0	66.65	0	0	11.4
2015	7	16	7	3	24	31		0	0	0	0	0	0	66.61	0	0	11.6
2015	7	16	7	13	24	33		0	0	0	0	0	0	66.56	0	0	11.6
2015	7	16	7	23	24	33		0	0	0	0	0	0	66.54	0	0	11.8
2015	7	16	7	33	24	32		0	0	0	0	0	0	66.52	0	0	12
2015	7	16	7	43	24	32		0	0	0	0	0	0	66.49	0	0	12.2
2015	7	16	7	53	24	33		0	0	0	0	0	0	66.49	0	0	12.4
2015	7	16	8	3	24	32		0	0	0	0	0	0	66.47	0	0	12.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	16	8	13	24	33		0	0	0	0	0	0	66.47	0	0	12.4
2015	7	16	8	23	24	32		0	0	0	0	0	0	66.47	0	0	12.4
2015	7	16	8	33	24	32		0	0	0	0	0	0	66.47	0	0	12.4
2015	7	16	8	43	24	32		0	0	0	0	0	0	66.49	0	0	12.4
2015	7	16	8	53	24	33		0	0	0	0	0	0	66.51	0	0	12.4
2015	7	16	9	3	24	32		0	0	0	0	0	0	66.52	0	0	12.6
2015	7	16	9	13	24	33		0	0	0	0	0	0	66.54	0	0	12.6
2015	7	16	9	23	24	33		0	0	0	0	0	0	66.58	0	0	12.6
2015	7	16	9	33	24	33		0	0	0	0	0	0	66.6	0	0	12.8
2015	7	16	9	43	24	33		0	0	0	0	0	0	66.63	0	0	12.8
2015	7	16	9	53	24	33		0	0	0	0	0	0	66.65	0	0	12.8
2015	7	16	10	3	24	32		0	0	0	0	0	0	66.72	0	0	12.8
2015	7	16	10	13	24	33		0	0	0	0	0	0	66.74	0	0	12.8
2015	7	16	10	23	24	33		0	0	0	0	0	0	66.79	0	0	12.8
2015	7	16	10	33	24	32		0	0	0	0	0	0	66.85	0	0	13.2
2015	7	16	10	43	24	32		0	0	0	0	0	0	66.9	0	0	13
2015	7	16	10	53	24	33		0	0	0	0	0	0	66.94	0	0	13
2015	7	16	11	3	24	33		0	0	0	0	0	0	66.99	0	0	13
2015	7	16	11	13	24	33		0	0	0	0	0	0	67.05	0	0	13
2015	7	16	11	23	24	33		0	0	0	0	0	0	67.1	0	0	12.8
2015	7	16	11	33	24	32		0	0	0	0	0	0	67.17	0	0	13
2015	7	16	11	43	24	33		0	0	0	0	0	0	67.23	0	0	12.8
2015	7	16	11	53	24	33		0	0	0	0	0	0	67.3	0	0	12.8
2015	7	16	12	3	24	32		0	0	0	0	0	0	67.35	0	0	12.8
2015	7	16	12	13	24	32		0	0	0	0	0	0	67.42	0	0	12.8
2015	7	16	12	23	24	32		0	0	0	0	0	0	67.48	0	0	12.8
2015	7	16	12	33	24	32		0	0	0	0	0	0	67.55	0	0	12.8
2015	7	16	12	43	24	32		0	0	0	0	0	0	67.6	0	0	12.8
2015	7	16	12	53	24	32		0	0	0	0	0	0	67.68	0	0	12.8
2015	7	16	13	3	24	32		0	0	0	0	0	0	67.73	0	0	12.8
2015	7	16	13	13	24	32		0	0	0	0	0	0	67.82	0	0	12.8
2015	7	16	13	23	24	32		0	0	0	0	0	0	67.86	0	0	12.8
2015	7	16	13	33	24	32		0	0	0	0	0	0	67.93	0	0	12.8
2015	7	16	13	43	24	32		0	0	0	0	0	0	68	0	0	13
2015	7	16	13	53	24	32		0	0	0	0	0	0	68.05	0	0	12.8
2015	7	16	14	3	24	32		0	0	0	0	0	0	68.13	0	0	12.8
2015	7	16	14	13	24	32		0	0	0	0	0	0	68.16	0	0	12.8
2015	7	16	14	23	24	32		0	0	0	0	0	0	68.22	0	0	12.8
2015	7	16	14	33	24	33		0	0	0	0	0	0	68.25	0	0	13
2015	7	16	14	43	24	32		0	0	0	0	0	0	68.31	0	0	13
2015	7	16	14	53	24	32		0	0	0	0	0	0	68.34	0	0	13
2015	7	16	15	3	24	32		0	0	0	0	0	0	68.4	0	0	12.8
2015	7	16	15	13	24	32		0	0	0	0	0	0	68.43	0	0	12.8
2015	7	16	15	23	24	32		0	0	0	0	0	0	68.45	0	0	12.8
2015	7	16	15	33	24	32		0	0	0	0	0	0	68.49	0	0	12.8
2015	7	16	15	43	24	33		0	0	0	0	0	0	68.52	0	0	12.8
2015	7	16	15	53	24	33		0	0	0	0	0	0	68.54	0	0	12.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	16	16	3	24	33	0	0	0	0	0	0	0	68.56	0	0	12.8
2015	7	16	16	13	24	32	0	0	0	0	0	0	0	68.58	0	0	12.8
2015	7	16	16	23	24	32	0	0	0	0	0	0	0	68.58	0	0	12.6
2015	7	16	16	33	24	32	0	0	0	0	0	0	0	68.59	0	0	12.6
2015	7	16	16	43	24	32	0	0	0	0	0	0	0	68.61	0	0	12.4
2015	7	16	16	53	24	32	0	0	0	0	0	0	0	68.61	0	0	12.4
2015	7	16	17	3	24	32	0	0	0	0	0	0	0	68.63	0	0	12.4
2015	7	16	17	13	24	32	0	0	0	0	0	0	0	68.61	0	0	12.2
2015	7	16	17	23	24	32	0	0	0	0	0	0	0	68.61	0	0	12.2
2015	7	16	17	33	24	32	0	0	0	0	0	0	0	68.61	0	0	12
2015	7	16	17	43	24	32	0	0	0	0	0	0	0	68.59	0	0	12
2015	7	16	17	53	24	33	0	0	0	0	0	0	0	68.59	0	0	12
2015	7	16	18	3	24	32	0	0	0	0	0	0	0	68.59	0	0	11.8
2015	7	16	18	13	24	33	0	0	0	0	0	0	0	68.59	0	0	11.4
2015	7	16	18	23	24	33	0	0	0	0	0	0	0	68.59	0	0	11.4
2015	7	16	18	33	24	32	0	0	0	0	0	0	0	68.59	0	0	11.8
2015	7	16	18	43	24	32	0	0	0	0	0	0	0	68.59	0	0	11.8
2015	7	16	18	53	24	33	0	0	0	0	0	0	0	68.59	0	0	11.8
2015	7	16	19	3	24	33	0	0	0	0	0	0	0	68.59	0	0	11.8
2015	7	16	19	13	24	33	0	0	0	0	0	0	0	68.58	0	0	11.8
2015	7	16	19	23	24	32	0	0	0	0	0	0	0	68.59	0	0	11.8
2015	7	16	19	33	24	33	0	0	0	0	0	0	0	68.58	0	0	11.8
2015	7	16	19	43	24	33	0	0	0	0	0	0	0	68.58	0	0	11.8
2015	7	16	19	53	24	33	0	0	0	0	0	0	0	68.58	0	0	11.8
2015	7	16	20	3	24	33	0	0	0	0	0	0	0	68.56	0	0	11.8
2015	7	16	20	13	24	33	0	0	0	0	0	0	0	68.56	0	0	11.8
2015	7	16	20	23	24	32	0	0	0	0	0	0	0	68.54	0	0	11.8
2015	7	16	20	33	24	33	0	0	0	0	0	0	0	68.52	0	0	11.8
2015	7	16	20	43	24	32	0	0	0	0	0	0	0	68.52	0	0	11.8
2015	7	16	20	53	24	32	0	0	0	0	0	0	0	68.5	0	0	11.8
2015	7	16	21	3	24	32	0	0	0	0	0	0	0	68.5	0	0	11.8
2015	7	16	21	13	24	33	0	0	0	0	0	0	0	68.49	0	0	11.8
2015	7	16	21	23	24	32	0	0	0	0	0	0	0	68.47	0	0	11.8
2015	7	16	21	33	24	33	0	0	0	0	0	0	0	68.45	0	0	11.8
2015	7	16	21	43	24	33	0	0	0	0	0	0	0	68.43	0	0	11.8
2015	7	16	21	53	24	33	0	0	0	0	0	0	0	68.41	0	0	11.8
2015	7	16	22	3	24	32	0	0	0	0	0	0	0	68.4	0	0	11.8
2015	7	16	22	13	24	32	0	0	0	0	0	0	0	68.38	0	0	11.8
2015	7	16	22	23	24	33	0	0	0	0	0	0	0	68.36	0	0	11.8
2015	7	16	22	33	24	33	0	0	0	0	0	0	0	68.34	0	0	11.8
2015	7	16	22	43	24	32	0	0	0	0	0	0	0	68.32	0	0	11.8
2015	7	16	22	53	24	32	0	0	0	0	0	0	0	68.31	0	0	11.8
2015	7	16	23	3	24	32	0	0	0	0	0	0	0	68.29	0	0	11.8
2015	7	16	23	13	24	32	0	0	0	0	0	0	0	68.27	0	0	11.8
2015	7	16	23	23	24	32	0	0	0	0	0	0	0	68.25	0	0	11.8
2015	7	16	23	33	24	32	0	0	0	0	0	0	0	68.23	0	0	11.8
2015	7	16	23	43	24	32	0	0	0	0	0	0	0	68.2	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	16	23	53	24	33		0	0	0	0	0	0	68.2	0	0	11.8
2015	7	17	0	3	24	33		0	0	0	0	0	0	68.18	0	0	11.8
2015	7	17	0	13	24	32		0	0	0	0	0	0	68.16	0	0	11.6
2015	7	17	0	23	24	32		0	0	0	0	0	0	68.13	0	0	11.6
2015	7	17	0	33	24	33		0	0	0	0	0	0	68.13	0	0	11.6
2015	7	17	0	43	24	32		0	0	0	0	0	0	68.11	0	0	11.6
2015	7	17	0	53	24	32		0	0	0	0	0	0	68.07	0	0	11.6
2015	7	17	1	3	24	32		0	0	0	0	0	0	68.07	0	0	11.6
2015	7	17	1	13	24	33		0	0	0	0	0	0	68.05	0	0	11.6
2015	7	17	1	23	24	32		0	0	0	0	0	0	68.04	0	0	11.6
2015	7	17	1	33	24	32		0	0	0	0	0	0	68.02	0	0	11.6
2015	7	17	1	43	24	33		0	0	0	0	0	0	67.98	0	0	11.6
2015	7	17	1	53	24	32		0	0	0	0	0	0	67.96	0	0	11.6
2015	7	17	2	3	24	32		0	0	0	0	0	0	67.95	0	0	11.6
2015	7	17	2	13	24	32		0	0	0	0	0	0	67.93	0	0	11.6
2015	7	17	2	23	24	33		0	0	0	0	0	0	67.89	0	0	11.6
2015	7	17	2	33	24	32		0	0	0	0	0	0	67.86	0	0	11.6
2015	7	17	2	43	24	32		0	0	0	0	0	0	67.84	0	0	11.6
2015	7	17	2	53	24	32		0	0	0	0	0	0	67.8	0	0	11.6
2015	7	17	3	3	24	33		0	0	0	0	0	0	67.77	0	0	11.6
2015	7	17	3	13	24	32		0	0	0	0	0	0	67.73	0	0	11.6
2015	7	17	3	23	24	32		0	0	0	0	0	0	67.69	0	0	11.6
2015	7	17	3	33	24	33		0	0	0	0	0	0	67.64	0	0	11.6
2015	7	17	3	43	24	32		0	0	0	0	0	0	67.59	0	0	11.6
2015	7	17	3	53	24	32		0	0	0	0	0	0	67.55	0	0	11.6
2015	7	17	4	3	24	33		0	0	0	0	0	0	67.51	0	0	11.6
2015	7	17	4	13	24	33		0	0	0	0	0	0	67.46	0	0	11.6
2015	7	17	4	23	24	33		0	0	0	0	0	0	67.41	0	0	11.6
2015	7	17	4	33	24	32		0	0	0	0	0	0	67.35	0	0	11.6
2015	7	17	4	43	24	32		0	0	0	0	0	0	67.32	0	0	11.6
2015	7	17	4	53	24	33		0	0	0	0	0	0	67.26	0	0	11.6
2015	7	17	5	3	24	33		0	0	0	0	0	0	67.21	0	0	11.6
2015	7	17	5	13	24	32		0	0	0	0	0	0	67.15	0	0	11.6
2015	7	17	5	23	24	33		0	0	0	0	0	0	67.1	0	0	11.6
2015	7	17	5	33	24	32		0	0	0	0	0	0	67.05	0	0	11.6
2015	7	17	5	43	24	33		0	0	0	0	0	0	66.97	0	0	11.6
2015	7	17	5	53	24	33		0	0	0	0	0	0	66.94	0	0	11.6
2015	7	17	6	3	24	33		0	0	0	0	0	0	66.87	0	0	11.6
2015	7	17	6	13	24	32		0	0	0	0	0	0	66.81	0	0	11.6
2015	7	17	6	23	24	32		0	0	0	0	0	0	66.76	0	0	11.6
2015	7	17	6	33	24	32		0	0	0	0	0	0	66.7	0	0	11.6
2015	7	17	6	43	24	32		0	0	0	0	0	0	66.65	0	0	11.6
2015	7	17	6	53	24	33		0	0	0	0	0	0	66.6	0	0	11.6
2015	7	17	7	3	24	32		0	0	0	0	0	0	66.54	0	0	11.6
2015	7	17	7	13	24	33		0	0	0	0	0	0	66.51	0	0	11.8
2015	7	17	7	23	24	33		0	0	0	0	0	0	66.47	0	0	11.8
2015	7	17	7	33	24	33		0	0	0	0	0	0	66.45	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	17	7	43	24	32		0	0	0	0	0	0	66.43	0	0	11.8
2015	7	17	7	53	24	33		0	0	0	0	0	0	66.4	0	0	11.8
2015	7	17	8	3	24	32		0	0	0	0	0	0	66.4	0	0	12
2015	7	17	8	13	24	33		0	0	0	0	0	0	66.38	0	0	12
2015	7	17	8	23	24	33		0	0	0	0	0	0	66.4	0	0	12
2015	7	17	8	33	24	33		0	0	0	0	0	0	66.38	0	0	12
2015	7	17	8	43	24	33		0	0	0	0	0	0	66.42	0	0	12
2015	7	17	8	53	24	33		0	0	0	0	0	0	66.42	0	0	12
2015	7	17	9	3	24	32		0	0	0	0	0	0	66.43	0	0	12
2015	7	17	9	13	24	32		0	0	0	0	0	0	66.47	0	0	12
2015	7	17	9	23	24	32		0	0	0	0	0	0	66.51	0	0	12
2015	7	17	9	33	24	33		0	0	0	0	0	0	66.54	0	0	12
2015	7	17	9	43	24	32		0	0	0	0	0	0	66.56	0	0	12
2015	7	17	9	53	24	33		0	0	0	0	0	0	66.63	0	0	12
2015	7	17	10	3	24	33		0	0	0	0	0	0	66.67	0	0	12
2015	7	17	10	13	24	32		0	0	0	0	0	0	66.7	0	0	12.2
2015	7	17	10	23	24	33		0	0	0	0	0	0	66.76	0	0	13
2015	7	17	10	33	24	33		0	0	0	0	0	0	66.81	0	0	13
2015	7	17	10	43	24	32		0	0	0	0	0	0	66.87	0	0	12.8
2015	7	17	10	53	24	32		0	0	0	0	0	0	66.92	0	0	12.8
2015	7	17	11	3	24	32		0	0	0	0	0	0	66.96	0	0	12.8
2015	7	17	11	13	24	32		0	0	0	0	0	0	67.03	0	0	12.8
2015	7	17	11	23	24	32		0	0	0	0	0	0	67.08	0	0	12.8
2015	7	17	11	33	24	33		0	0	0	0	0	0	67.14	0	0	12.8
2015	7	17	11	43	24	32		0	0	0	0	0	0	67.21	0	0	12.8
2015	7	17	11	53	24	32		0	0	0	0	0	0	67.26	0	0	12.8
2015	7	17	12	3	24	32		0	0	0	0	0	0	67.32	0	0	12.8
2015	7	17	12	13	24	33		0	0	0	0	0	0	67.41	0	0	12.8
2015	7	17	12	23	24	33		0	0	0	0	0	0	67.42	0	0	12.6
2015	7	17	12	33	24	32		0	0	0	0	0	0	67.51	0	0	13.2
2015	7	17	12	43	24	32		0	0	0	0	0	0	67.59	0	0	13
2015	7	17	12	53	24	33		0	0	0	0	0	0	67.64	0	0	13
2015	7	17	13	3	24	33		0	0	0	0	0	0	67.69	0	0	13
2015	7	17	13	13	24	33		0	0	0	0	0	0	67.77	0	0	13.2
2015	7	17	13	23	24	33		0	0	0	0	0	0	67.82	0	0	13.8
2015	7	17	13	33	24	32		0	0	0	0	0	0	67.86	0	0	14
2015	7	17	13	43	24	32		0	0	0	0	0	0	67.89	0	0	14
2015	7	17	13	53	24	32		0	0	0	0	0	0	67.96	0	0	14
2015	7	17	14	3	24	33		0	0	0	0	0	0	68.02	0	0	14
2015	7	17	14	13	24	32		0	0	0	0	0	0	68.05	0	0	13.8
2015	7	17	14	23	24	32		0	0	0	0	0	0	68.11	0	0	13.6
2015	7	17	14	33	24	32		0	0	0	0	0	0	68.13	0	0	14
2015	7	17	14	43	24	32		0	0	0	0	0	0	68.16	0	0	13.4
2015	7	17	14	53	24	32		0	0	0	0	0	0	68.16	0	0	13.2
2015	7	17	15	3	24	32		0	0	0	0	0	0	68.23	0	0	13.2
2015	7	17	15	13	24	33		0	0	0	0	0	0	68.27	0	0	13.2
2015	7	17	15	23	24	32		0	0	0	0	0	0	68.31	0	0	13.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	17	15	33	24	33		0	0	0	0	0	0	68.32	0	0	13.2
2015	7	17	15	43	24	32		0	0	0	0	0	0	68.34	0	0	13
2015	7	17	15	53	24	32		0	0	0	0	0	0	68.36	0	0	13
2015	7	17	16	3	24	32		0	0	0	0	0	0	68.38	0	0	13
2015	7	17	16	13	24	32		0	0	0	0	0	0	68.38	0	0	13
2015	7	17	16	23	24	32		0	0	0	0	0	0	68.4	0	0	12.8
2015	7	17	16	33	24	32		0	0	0	0	0	0	68.4	0	0	12.8
2015	7	17	16	43	24	32		0	0	0	0	0	0	68.4	0	0	12.6
2015	7	17	16	53	24	32		0	0	0	0	0	0	68.4	0	0	12.6
2015	7	17	17	3	24	32		0	0	0	0	0	0	68.41	0	0	12.4
2015	7	17	17	13	24	32		0	0	0	0	0	0	68.4	0	0	12.4
2015	7	17	17	23	24	33		0	0	0	0	0	0	68.38	0	0	12.2
2015	7	17	17	33	24	32		0	0	0	0	0	0	68.36	0	0	12
2015	7	17	17	43	24	32		0	0	0	0	0	0	68.34	0	0	11.8
2015	7	17	17	53	24	33		0	0	0	0	0	0	68.34	0	0	11.8
2015	7	17	18	3	24	33		0	0	0	0	0	0	68.32	0	0	11.2
2015	7	17	18	13	24	32		0	0	0	0	0	0	68.32	0	0	11.2
2015	7	17	18	23	24	32		0	0	0	0	0	0	68.32	0	0	11.2
2015	7	17	18	33	24	33		0	0	0	0	0	0	68.31	0	0	11.2
2015	7	17	18	43	24	33		0	0	0	0	0	0	68.31	0	0	11
2015	7	17	18	53	24	33		0	0	0	0	0	0	68.31	0	0	11
2015	7	17	19	3	24	32		0	0	0	0	0	0	68.31	0	0	11
2015	7	17	19	13	24	32		0	0	0	0	0	0	68.29	0	0	10.8
2015	7	17	19	23	24	32		0	0	0	0	0	0	68.29	0	0	10.8
2015	7	17	19	33	24	32		0	0	0	0	0	0	68.29	0	0	10.6
2015	7	17	19	43	24	32		0	0	0	0	0	0	68.29	0	0	10.4
2015	7	17	19	53	24	32		0	0	0	0	0	0	68.29	0	0	10.4
2015	7	17	20	3	24	32		0	0	0	0	0	0	68.29	0	0	10.4
2015	7	17	20	13	24	32		0	0	0	0	0	0	68.29	0	0	10.2
2015	7	17	20	23	24	32		0	0	0	0	0	0	68.29	0	0	10.2
2015	7	17	20	33	24	31		0	0	0	0	0	0	68.29	0	0	11.8
2015	7	17	20	43	24	32		0	0	0	0	0	0	68.29	0	0	11.8
2015	7	17	20	53	24	32		0	0	0	0	0	0	68.27	0	0	11.8
2015	7	17	21	3	24	32		0	0	0	0	0	0	68.27	0	0	11.8
2015	7	17	21	13	24	34		0	0	0	0	0	0	68.27	0	0	11.8
2015	7	17	21	23	24	33		0	0	0	0	0	0	68.25	0	0	11.8
2015	7	17	21	33	24	32		0	0	0	0	0	0	68.23	0	0	11.8
2015	7	17	21	43	24	32		0	0	0	0	0	0	68.22	0	0	11.8
2015	7	17	21	53	24	33		0	0	0	0	0	0	68.22	0	0	11.8
2015	7	17	22	3	24	33		0	0	0	0	0	0	68.18	0	0	11.8
2015	7	17	22	13	24	32		0	0	0	0	0	0	68.18	0	0	11.8
2015	7	17	22	23	24	32		0	0	0	0	0	0	68.16	0	0	11.8
2015	7	17	22	33	24	32		0	0	0	0	0	0	68.14	0	0	11.8
2015	7	17	22	43	24	32		0	0	0	0	0	0	68.13	0	0	11.8
2015	7	17	22	53	24	33		0	0	0	0	0	0	68.11	0	0	11.8
2015	7	17	23	3	24	32		0	0	0	0	0	0	68.09	0	0	11.8
2015	7	17	23	13	24	33		0	0	0	0	0	0	68.09	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	17	23	23	24	32		0	0	0	0	0	0	68.07	0	0	11.8
2015	7	17	23	33	24	32		0	0	0	0	0	0	68.05	0	0	11.8
2015	7	17	23	43	24	32		0	0	0	0	0	0	68.02	0	0	11.8
2015	7	17	23	53	24	33		0	0	0	0	0	0	68	0	0	11.8
2015	7	18	0	3	24	33		0	0	0	0	0	0	67.98	0	0	11.8
2015	7	18	0	13	24	33		0	0	0	0	0	0	67.96	0	0	11.8
2015	7	18	0	23	24	32		0	0	0	0	0	0	67.96	0	0	11.8
2015	7	18	0	33	24	32		0	0	0	0	0	0	67.95	0	0	11.8
2015	7	18	0	43	24	32		0	0	0	0	0	0	67.93	0	0	11.8
2015	7	18	0	53	24	33		0	0	0	0	0	0	67.91	0	0	11.8
2015	7	18	1	3	24	33		0	0	0	0	0	0	67.89	0	0	11.8
2015	7	18	1	13	24	33		0	0	0	0	0	0	67.87	0	0	11.6
2015	7	18	1	23	24	33		0	0	0	0	0	0	67.86	0	0	11.6
2015	7	18	1	33	24	33		0	0	0	0	0	0	67.84	0	0	11.6
2015	7	18	1	43	24	32		0	0	0	0	0	0	67.82	0	0	11.6
2015	7	18	1	53	24	33		0	0	0	0	0	0	67.8	0	0	11.6
2015	7	18	2	3	24	32		0	0	0	0	0	0	67.78	0	0	11.6
2015	7	18	2	13	24	32		0	0	0	0	0	0	67.75	0	0	11.6
2015	7	18	2	23	24	32		0	0	0	0	0	0	67.73	0	0	11.6
2015	7	18	2	33	24	32		0	0	0	0	0	0	67.71	0	0	11.6
2015	7	18	2	43	24	32		0	0	0	0	0	0	67.68	0	0	11.6
2015	7	18	2	53	24	32		0	0	0	0	0	0	67.66	0	0	11.6
2015	7	18	3	3	24	33		0	0	0	0	0	0	67.64	0	0	11.6
2015	7	18	3	13	24	32		0	0	0	0	0	0	67.62	0	0	11.6
2015	7	18	3	23	24	33		0	0	0	0	0	0	67.59	0	0	11.6
2015	7	18	3	33	24	33		0	0	0	0	0	0	67.57	0	0	11.6
2015	7	18	3	43	24	32		0	0	0	0	0	0	67.55	0	0	11.6
2015	7	18	3	53	24	32		0	0	0	0	0	0	67.53	0	0	11.6
2015	7	18	4	3	24	33		0	0	0	0	0	0	67.5	0	0	11.6
2015	7	18	4	13	24	32		0	0	0	0	0	0	67.46	0	0	11.6
2015	7	18	4	23	24	32		0	0	0	0	0	0	67.44	0	0	11.6
2015	7	18	4	33	24	32		0	0	0	0	0	0	67.41	0	0	11.6
2015	7	18	4	43	24	33		0	0	0	0	0	0	67.37	0	0	11.6
2015	7	18	4	53	24	32		0	0	0	0	0	0	67.33	0	0	11.6
2015	7	18	5	3	24	33		0	0	0	0	0	0	67.28	0	0	11.6
2015	7	18	5	13	24	32		0	0	0	0	0	0	67.24	0	0	11.6
2015	7	18	5	23	24	32		0	0	0	0	0	0	67.19	0	0	11.6
2015	7	18	5	33	24	33		0	0	0	0	0	0	67.15	0	0	11.6
2015	7	18	5	43	24	33		0	0	0	0	0	0	67.08	0	0	11.6
2015	7	18	5	53	24	32		0	0	0	0	0	0	67.05	0	0	11.6
2015	7	18	6	3	24	32		0	0	0	0	0	0	66.99	0	0	11.6
2015	7	18	6	13	24	32		0	0	0	0	0	0	66.94	0	0	11.6
2015	7	18	6	23	24	32		0	0	0	0	0	0	66.88	0	0	11.6
2015	7	18	6	33	24	33		0	0	0	0	0	0	66.83	0	0	11.6
2015	7	18	6	43	24	32		0	0	0	0	0	0	66.78	0	0	11.6
2015	7	18	6	53	24	33		0	0	0	0	0	0	66.74	0	0	11.6
2015	7	18	7	3	24	33		0	0	0	0	0	0	66.67	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	18	7	7	13	24	33	0	0	0	0	0	0	66.63	0	0	11.8
2015	7	18	7	23	24	33		0	0	0	0	0	0	66.61	0	0	11.8
2015	7	18	7	33	24	32		0	0	0	0	0	0	66.58	0	0	11.8
2015	7	18	7	43	24	33		0	0	0	0	0	0	66.56	0	0	11.8
2015	7	18	7	53	24	33		0	0	0	0	0	0	66.56	0	0	11.8
2015	7	18	8	3	24	32		0	0	0	0	0	0	66.56	0	0	11.8
2015	7	18	8	13	24	32		0	0	0	0	0	0	66.54	0	0	12
2015	7	18	8	23	24	33		0	0	0	0	0	0	66.56	0	0	12
2015	7	18	8	33	24	32		0	0	0	0	0	0	66.56	0	0	12
2015	7	18	8	43	24	33		0	0	0	0	0	0	66.58	0	0	12
2015	7	18	8	53	24	32		0	0	0	0	0	0	66.6	0	0	12
2015	7	18	9	3	24	33		0	0	0	0	0	0	66.61	0	0	12.2
2015	7	18	9	13	24	33		0	0	0	0	0	0	66.63	0	0	12.4
2015	7	18	9	23	24	33		0	0	0	0	0	0	66.69	0	0	13
2015	7	18	9	33	24	33		0	0	0	0	0	0	66.7	0	0	13
2015	7	18	9	43	24	32		0	0	0	0	0	0	66.74	0	0	12.8
2015	7	18	9	53	24	31		0	0	0	0	0	0	66.79	0	0	12.8
2015	7	18	10	3	24	33		0	0	0	0	0	0	66.83	0	0	13
2015	7	18	10	13	24	33		0	0	0	0	0	0	66.88	0	0	12.8
2015	7	18	10	23	24	33		0	0	0	0	0	0	66.92	0	0	12.8
2015	7	18	10	33	24	33		0	0	0	0	0	0	66.97	0	0	13
2015	7	18	10	43	24	33		0	0	0	0	0	0	67.03	0	0	13
2015	7	18	10	53	24	33		0	0	0	0	0	0	67.1	0	0	13
2015	7	18	11	3	24	33		0	0	0	0	0	0	67.15	0	0	13
2015	7	18	11	13	24	32		0	0	0	0	0	0	67.21	0	0	12.8
2015	7	18	11	23	24	33		0	0	0	0	0	0	67.28	0	0	12.8
2015	7	18	11	33	24	33		0	0	0	0	0	0	67.33	0	0	13
2015	7	18	11	43	24	33		0	0	0	0	0	0	67.39	0	0	13
2015	7	18	11	53	24	33		0	0	0	0	0	0	67.44	0	0	12.8
2015	7	18	12	3	24	32		0	0	0	0	0	0	67.51	0	0	12.8
2015	7	18	12	13	24	32		0	0	0	0	0	0	67.59	0	0	12.8
2015	7	18	12	23	24	33		0	0	0	0	0	0	67.64	0	0	12.8
2015	7	18	12	33	24	33		0	0	0	0	0	0	67.71	0	0	13
2015	7	18	12	43	24	32		0	0	0	0	0	0	67.77	0	0	12.8
2015	7	18	12	53	24	33		0	0	0	0	0	0	67.84	0	0	12.8
2015	7	18	13	3	24	32		0	0	0	0	0	0	67.91	0	0	12.8
2015	7	18	13	13	24	33		0	0	0	0	0	0	67.98	0	0	13
2015	7	18	13	23	24	33		0	0	0	0	0	0	68.04	0	0	13
2015	7	18	13	33	24	33		0	0	0	0	0	0	68.04	0	0	13.8
2015	7	18	13	43	24	32		0	0	0	0	0	0	67.84	0	0	13.4
2015	7	18	13	53	24	33		0	0	0	0	0	0	67.86	0	0	12.2
2015	7	18	14	3	24	33		0	0	0	0	0	0	67.8	0	0	12.2
2015	7	18	14	13	24	32		0	0	0	0	0	0	67.96	0	0	12.4
2015	7	18	14	23	24	33		0	0	0	0	0	0	67.86	0	0	12
2015	7	18	14	33	24	33		0	0	0	0	0	0	67.87	0	0	12.2
2015	7	18	14	43	24	32		0	0	0	0	0	0	67.84	0	0	12
2015	7	18	14	53	24	32		0	0	0	0	0	0	67.82	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	18	15	3	24	32		0	0	0	0	0	0	67.82	0	0	12
2015	7	18	15	13	24	32		0	0	0	0	0	0	68	0	0	12.4
2015	7	18	15	23	24	32		0	0	0	0	0	0	68.05	0	0	12.4
2015	7	18	15	33	24	32		0	0	0	0	0	0	68.04	0	0	12.2
2015	7	18	15	43	24	32		0	0	0	0	0	0	68.05	0	0	12.2
2015	7	18	15	53	24	32		0	0	0	0	0	0	68.07	0	0	12.2
2015	7	18	16	3	24	33		0	0	0	0	0	0	68.11	0	0	12.4
2015	7	18	16	13	24	32		0	0	0	0	0	0	68.09	0	0	12.2
2015	7	18	16	23	24	33		0	0	0	0	0	0	68	0	0	12.2
2015	7	18	16	33	24	32		0	0	0	0	0	0	67.98	0	0	12
2015	7	18	16	43	24	32		0	0	0	0	0	0	67.93	0	0	12
2015	7	18	16	53	24	33		0	0	0	0	0	0	67.87	0	0	12
2015	7	18	17	3	24	32		0	0	0	0	0	0	67.84	0	0	12
2015	7	18	17	13	24	32		0	0	0	0	0	0	67.82	0	0	12
2015	7	18	17	23	24	32		0	0	0	0	0	0	67.78	0	0	11.8
2015	7	18	17	33	24	32		0	0	0	0	0	0	67.77	0	0	11.8
2015	7	18	17	43	24	33		0	0	0	0	0	0	67.77	0	0	11.8
2015	7	18	17	53	24	33		0	0	0	0	0	0	67.75	0	0	11.8
2015	7	18	18	3	24	32		0	0	0	0	0	0	67.73	0	0	11.8
2015	7	18	18	13	24	32		0	0	0	0	0	0	67.71	0	0	11.8
2015	7	18	18	23	24	32		0	0	0	0	0	0	67.69	0	0	11.8
2015	7	18	18	33	24	33		0	0	0	0	0	0	67.69	0	0	11.8
2015	7	18	18	43	24	32		0	0	0	0	0	0	67.68	0	0	11.8
2015	7	18	18	53	24	33		0	0	0	0	0	0	67.66	0	0	11.8
2015	7	18	19	3	24	33		0	0	0	0	0	0	67.66	0	0	11.8
2015	7	18	19	13	24	32		0	0	0	0	0	0	67.64	0	0	11.8
2015	7	18	19	23	24	32		0	0	0	0	0	0	67.64	0	0	11.8
2015	7	18	19	33	24	33		0	0	0	0	0	0	67.6	0	0	11.8
2015	7	18	19	43	24	32		0	0	0	0	0	0	67.59	0	0	11.8
2015	7	18	19	53	24	33		0	0	0	0	0	0	67.59	0	0	11.8
2015	7	18	20	3	24	32		0	0	0	0	0	0	67.55	0	0	11.8
2015	7	18	20	13	24	33		0	0	0	0	0	0	67.53	0	0	11.8
2015	7	18	20	23	24	32		0	0	0	0	0	0	67.53	0	0	11.8
2015	7	18	20	33	24	33		0	0	0	0	0	0	67.5	0	0	11.8
2015	7	18	20	43	24	32		0	0	0	0	0	0	67.48	0	0	11.8
2015	7	18	20	53	24	32		0	0	0	0	0	0	67.46	0	0	11.8
2015	7	18	21	3	24	33		0	0	0	0	0	0	67.44	0	0	11.8
2015	7	18	21	13	24	32		0	0	0	0	0	0	67.42	0	0	11.8
2015	7	18	21	23	24	34		0	0	0	0	0	0	67.41	0	0	11.8
2015	7	18	21	33	24	31		0	0	0	0	0	0	67.39	0	0	11.8
2015	7	18	21	43	24	32		0	0	0	0	0	0	67.37	0	0	11.8
2015	7	18	21	53	24	32		0	0	0	0	0	0	67.37	0	0	11.8
2015	7	18	22	3	24	33		0	0	0	0	0	0	67.35	0	0	11.8
2015	7	18	22	13	24	32		0	0	0	0	0	0	67.33	0	0	11.8
2015	7	18	22	23	24	33		0	0	0	0	0	0	67.32	0	0	11.8
2015	7	18	22	33	24	32		0	0	0	0	0	0	67.32	0	0	11.8
2015	7	18	22	43	24	32		0	0	0	0	0	0	67.3	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	18	22	53	24	33		0	0	0	0	0	0	67.28	0	0	11.8
2015	7	18	23	3	24	32		0	0	0	0	0	0	67.26	0	0	11.8
2015	7	18	23	13	24	33		0	0	0	0	0	0	67.24	0	0	11.8
2015	7	18	23	23	24	32		0	0	0	0	0	0	67.23	0	0	11.8
2015	7	18	23	33	24	32		0	0	0	0	0	0	67.21	0	0	11.8
2015	7	18	23	43	24	33		0	0	0	0	0	0	67.19	0	0	11.6
2015	7	18	23	53	24	32		0	0	0	0	0	0	67.17	0	0	11.6
2015	7	19	0	3	24	32		0	0	0	0	0	0	67.15	0	0	11.6
2015	7	19	0	13	24	33		0	0	0	0	0	0	67.14	0	0	11.6
2015	7	19	0	23	24	33		0	0	0	0	0	0	67.12	0	0	11.6
2015	7	19	0	33	24	32		0	0	0	0	0	0	67.1	0	0	11.6
2015	7	19	0	43	24	33		0	0	0	0	0	0	67.06	0	0	11.6
2015	7	19	0	53	24	33		0	0	0	0	0	0	67.05	0	0	11.6
2015	7	19	1	3	24	32		0	0	0	0	0	0	67.01	0	0	11.6
2015	7	19	1	13	24	33		0	0	0	0	0	0	67.01	0	0	11.6
2015	7	19	1	23	24	33		0	0	0	0	0	0	66.97	0	0	11.6
2015	7	19	1	33	24	32		0	0	0	0	0	0	66.96	0	0	11.6
2015	7	19	1	43	24	33		0	0	0	0	0	0	66.92	0	0	11.6
2015	7	19	1	53	24	32		0	0	0	0	0	0	66.9	0	0	11.6
2015	7	19	2	3	24	32		0	0	0	0	0	0	66.87	0	0	11.6
2015	7	19	2	13	24	33		0	0	0	0	0	0	66.85	0	0	11.6
2015	7	19	2	23	24	33		0	0	0	0	0	0	66.81	0	0	11.6
2015	7	19	2	33	24	33		0	0	0	0	0	0	66.78	0	0	11.6
2015	7	19	2	43	24	32		0	0	0	0	0	0	66.76	0	0	11.6
2015	7	19	2	53	24	33		0	0	0	0	0	0	66.74	0	0	11.6
2015	7	19	3	3	24	33		0	0	0	0	0	0	66.7	0	0	11.6
2015	7	19	3	13	24	33		0	0	0	0	0	0	66.69	0	0	11.6
2015	7	19	3	23	24	33		0	0	0	0	0	0	66.65	0	0	11.6
2015	7	19	3	33	24	32		0	0	0	0	0	0	66.61	0	0	11.6
2015	7	19	3	43	24	33		0	0	0	0	0	0	66.6	0	0	11.6
2015	7	19	3	53	24	32		0	0	0	0	0	0	66.56	0	0	11.6
2015	7	19	4	3	24	32		0	0	0	0	0	0	66.54	0	0	11.6
2015	7	19	4	13	24	32		0	0	0	0	0	0	66.49	0	0	11.6
2015	7	19	4	23	24	33		0	0	0	0	0	0	66.47	0	0	11.6
2015	7	19	4	33	24	33		0	0	0	0	0	0	66.43	0	0	11.6
2015	7	19	4	43	24	32		0	0	0	0	0	0	66.4	0	0	11.6
2015	7	19	4	53	24	32		0	0	0	0	0	0	66.38	0	0	11.6
2015	7	19	5	3	24	32		0	0	0	0	0	0	66.34	0	0	11.6
2015	7	19	5	13	24	33		0	0	0	0	0	0	66.33	0	0	11.6
2015	7	19	5	23	24	33		0	0	0	0	0	0	66.29	0	0	11.6
2015	7	19	5	33	24	32		0	0	0	0	0	0	66.27	0	0	11.6
2015	7	19	5	43	24	32		0	0	0	0	0	0	66.24	0	0	11.6
2015	7	19	5	53	24	33		0	0	0	0	0	0	66.22	0	0	11.6
2015	7	19	6	3	24	32		0	0	0	0	0	0	66.2	0	0	11.6
2015	7	19	6	13	24	32		0	0	0	0	0	0	66.16	0	0	11.6
2015	7	19	6	23	24	32		0	0	0	0	0	0	66.15	0	0	11.6
2015	7	19	6	33	24	33		0	0	0	0	0	0	66.13	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	19	6	43	24	32		0	0	0	0	0	0	66.09	0	0	11.6
2015	7	19	6	53	24	32		0	0	0	0	0	0	66.09	0	0	11.6
2015	7	19	7	3	24	32		0	0	0	0	0	0	66.09	0	0	11.8
2015	7	19	7	13	24	33		0	0	0	0	0	0	66.09	0	0	11.8
2015	7	19	7	23	24	33		0	0	0	0	0	0	66.09	0	0	11.8
2015	7	19	7	33	24	32		0	0	0	0	0	0	66.09	0	0	11.8
2015	7	19	7	43	24	32		0	0	0	0	0	0	66.09	0	0	11.8
2015	7	19	7	53	24	33		0	0	0	0	0	0	66.09	0	0	11.8
2015	7	19	8	3	24	33		0	0	0	0	0	0	66.09	0	0	12
2015	7	19	8	13	24	33		0	0	0	0	0	0	66.11	0	0	12
2015	7	19	8	23	24	33		0	0	0	0	0	0	66.13	0	0	12
2015	7	19	8	33	24	32		0	0	0	0	0	0	66.15	0	0	12
2015	7	19	8	43	24	33		0	0	0	0	0	0	66.16	0	0	12
2015	7	19	8	53	24	32		0	0	0	0	0	0	66.2	0	0	12.2
2015	7	19	9	3	24	33		0	0	0	0	0	0	66.22	0	0	12.2
2015	7	19	9	13	24	33		0	0	0	0	0	0	66.24	0	0	12.2
2015	7	19	9	23	24	33		0	0	0	0	0	0	66.25	0	0	12.2
2015	7	19	9	33	24	32		0	0	0	0	0	0	66.29	0	0	12.2
2015	7	19	9	43	24	32		0	0	0	0	0	0	66.34	0	0	12.4
2015	7	19	9	53	24	32		0	0	0	0	0	0	66.31	0	0	12.2
2015	7	19	10	3	24	33		0	0	0	0	0	0	66.38	0	0	12.4
2015	7	19	10	13	24	33		0	0	0	0	0	0	66.47	0	0	12.4
2015	7	19	10	23	24	33		0	0	0	0	0	0	66.54	0	0	12.4
2015	7	19	10	33	24	32		0	0	0	0	0	0	66.6	0	0	12.4
2015	7	19	10	43	24	32		0	0	0	0	0	0	66.63	0	0	13.8
2015	7	19	10	53	24	33		0	0	0	0	0	0	66.69	0	0	12.6
2015	7	19	11	3	24	32		0	0	0	0	0	0	66.72	0	0	13.4
2015	7	19	11	13	24	33		0	0	0	0	0	0	66.76	0	0	13.2
2015	7	19	11	23	24	33		0	0	0	0	0	0	66.87	0	0	13.4
2015	7	19	11	33	24	33		0	0	0	0	0	0	66.96	0	0	13
2015	7	19	11	43	24	33		0	0	0	0	0	0	66.96	0	0	13.2
2015	7	19	11	53	24	33		0	0	0	0	0	0	67.03	0	0	13.2
2015	7	19	12	3	24	33		0	0	0	0	0	0	67.1	0	0	13
2015	7	19	12	13	24	32		0	0	0	0	0	0	67.15	0	0	12.8
2015	7	19	12	23	24	32		0	0	0	0	0	0	67.24	0	0	12.8
2015	7	19	12	33	24	32		0	0	0	0	0	0	67.23	0	0	13.2
2015	7	19	12	43	24	33		0	0	0	0	0	0	67.33	0	0	13.2
2015	7	19	12	53	24	32		0	0	0	0	0	0	67.32	0	0	13.4
2015	7	19	13	3	24	33		0	0	0	0	0	0	67.35	0	0	13.4
2015	7	19	13	13	24	33		0	0	0	0	0	0	67.44	0	0	13.2
2015	7	19	13	23	24	32		0	0	0	0	0	0	67.53	0	0	12.8
2015	7	19	13	33	24	32		0	0	0	0	0	0	67.66	0	0	12.8
2015	7	19	13	43	24	33		0	0	0	0	0	0	67.73	0	0	12.8
2015	7	19	13	53	24	32		0	0	0	0	0	0	67.8	0	0	12.8
2015	7	19	14	3	24	32		0	0	0	0	0	0	67.84	0	0	12.8
2015	7	19	14	13	24	32		0	0	0	0	0	0	67.89	0	0	12.8
2015	7	19	14	23	24	33		0	0	0	0	0	0	67.95	0	0	12.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	19	14	33	24	33		0	0	0	0	0	0	67.98	0	0	12.4
2015	7	19	14	43	24	33		0	0	0	0	0	0	68.04	0	0	12.4
2015	7	19	14	53	24	32		0	0	0	0	0	0	68.07	0	0	12.4
2015	7	19	15	3	24	32		0	0	0	0	0	0	68.13	0	0	12.4
2015	7	19	15	13	24	32		0	0	0	0	0	0	68.22	0	0	12.4
2015	7	19	15	23	24	32		0	0	0	0	0	0	68.25	0	0	12.4
2015	7	19	15	33	24	32		0	0	0	0	0	0	68.29	0	0	12.8
2015	7	19	15	43	24	32		0	0	0	0	0	0	68.32	0	0	13
2015	7	19	15	53	24	32		0	0	0	0	0	0	68.34	0	0	12.8
2015	7	19	16	3	24	32		0	0	0	0	0	0	68.36	0	0	12.8
2015	7	19	16	13	24	32		0	0	0	0	0	0	68.36	0	0	12.4
2015	7	19	16	23	24	32		0	0	0	0	0	0	68.34	0	0	12.4
2015	7	19	16	33	24	32		0	0	0	0	0	0	68.4	0	0	12.2
2015	7	19	16	43	24	32		0	0	0	0	0	0	68.41	0	0	12.4
2015	7	19	16	53	24	32		0	0	0	0	0	0	68.34	0	0	12
2015	7	19	17	3	24	32		0	0	0	0	0	0	68.32	0	0	12
2015	7	19	17	13	24	32		0	0	0	0	0	0	68.34	0	0	12
2015	7	19	17	23	24	32		0	0	0	0	0	0	68.34	0	0	12
2015	7	19	17	33	24	32		0	0	0	0	0	0	68.38	0	0	12
2015	7	19	17	43	24	32		0	0	0	0	0	0	68.38	0	0	12
2015	7	19	17	53	24	33		0	0	0	0	0	0	68.36	0	0	12
2015	7	19	18	3	24	32		0	0	0	0	0	0	68.38	0	0	11.8
2015	7	19	18	13	24	32		0	0	0	0	0	0	68.36	0	0	11.8
2015	7	19	18	23	24	33		0	0	0	0	0	0	68.36	0	0	11.8
2015	7	19	18	33	24	33		0	0	0	0	0	0	68.36	0	0	11.8
2015	7	19	18	43	24	32		0	0	0	0	0	0	68.36	0	0	11.8
2015	7	19	18	53	24	32		0	0	0	0	0	0	68.38	0	0	11.8
2015	7	19	19	3	24	33		0	0	0	0	0	0	68.38	0	0	11.8
2015	7	19	19	13	24	33		0	0	0	0	0	0	68.38	0	0	11.8
2015	7	19	19	23	24	32		0	0	0	0	0	0	68.38	0	0	11.8
2015	7	19	19	33	24	32		0	0	0	0	0	0	68.38	0	0	11.8
2015	7	19	19	43	24	32		0	0	0	0	0	0	68.38	0	0	11.8
2015	7	19	19	53	24	32		0	0	0	0	0	0	68.38	0	0	11.8
2015	7	19	20	3	24	32		0	0	0	0	0	0	68.36	0	0	11.8
2015	7	19	20	13	24	32		0	0	0	0	0	0	68.36	0	0	11.8
2015	7	19	20	23	24	32		0	0	0	0	0	0	68.36	0	0	11.8
2015	7	19	20	33	24	33		0	0	0	0	0	0	68.36	0	0	11.8
2015	7	19	20	43	24	33		0	0	0	0	0	0	68.34	0	0	11.8
2015	7	19	20	53	24	32		0	0	0	0	0	0	68.34	0	0	11.8
2015	7	19	21	3	24	32		0	0	0	0	0	0	68.34	0	0	11.8
2015	7	19	21	13	24	32		0	0	0	0	0	0	68.32	0	0	11.8
2015	7	19	21	23	24	32		0	0	0	0	0	0	68.32	0	0	11.8
2015	7	19	21	33	24	32		0	0	0	0	0	0	68.31	0	0	11.8
2015	7	19	21	43	24	32		0	0	0	0	0	0	68.31	0	0	11.8
2015	7	19	21	53	24	32		0	0	0	0	0	0	68.29	0	0	11.8
2015	7	19	22	3	24	32		0	0	0	0	0	0	68.29	0	0	11.8
2015	7	19	22	13	24	32		0	0	0	0	0	0	68.27	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	19	22	23	24	33		0	0	0	0	0	0	68.27	0	0	11.8
2015	7	19	22	33	24	32		0	0	0	0	0	0	68.25	0	0	11.8
2015	7	19	22	43	24	32		0	0	0	0	0	0	68.25	0	0	11.8
2015	7	19	22	53	24	32		0	0	0	0	0	0	68.23	0	0	11.8
2015	7	19	23	3	24	32		0	0	0	0	0	0	68.23	0	0	11.8
2015	7	19	23	13	24	33		0	0	0	0	0	0	68.22	0	0	11.8
2015	7	19	23	23	24	33		0	0	0	0	0	0	68.2	0	0	11.8
2015	7	19	23	33	24	31		0	0	0	0	0	0	68.2	0	0	11.8
2015	7	19	23	43	24	32		0	0	0	0	0	0	68.18	0	0	11.8
2015	7	19	23	53	24	32		0	0	0	0	0	0	68.18	0	0	11.8
2015	7	20	0	3	24	33		0	0	0	0	0	0	68.18	0	0	11.8
2015	7	20	0	13	24	33		0	0	0	0	0	0	68.16	0	0	11.8
2015	7	20	0	23	24	32		0	0	0	0	0	0	68.14	0	0	11.8
2015	7	20	0	33	24	32		0	0	0	0	0	0	68.14	0	0	11.8
2015	7	20	0	43	24	31		0	0	0	0	0	0	68.14	0	0	11.8
2015	7	20	0	53	24	33		0	0	0	0	0	0	68.13	0	0	11.8
2015	7	20	1	3	24	32		0	0	0	0	0	0	68.11	0	0	11.8
2015	7	20	1	13	24	32		0	0	0	0	0	0	68.11	0	0	11.8
2015	7	20	1	23	24	32		0	0	0	0	0	0	68.07	0	0	11.8
2015	7	20	1	33	24	32		0	0	0	0	0	0	68.05	0	0	11.8
2015	7	20	1	43	24	32		0	0	0	0	0	0	68.04	0	0	11.8
2015	7	20	1	53	24	33		0	0	0	0	0	0	68.02	0	0	11.8
2015	7	20	2	3	24	33		0	0	0	0	0	0	68	0	0	11.8
2015	7	20	2	13	24	33		0	0	0	0	0	0	68	0	0	11.8
2015	7	20	2	23	24	32		0	0	0	0	0	0	67.98	0	0	11.8
2015	7	20	2	33	24	33		0	0	0	0	0	0	67.96	0	0	11.8
2015	7	20	2	43	24	32		0	0	0	0	0	0	67.95	0	0	11.8
2015	7	20	2	53	24	32		0	0	0	0	0	0	67.93	0	0	11.8
2015	7	20	3	3	24	32		0	0	0	0	0	0	67.91	0	0	11.6
2015	7	20	3	13	24	32		0	0	0	0	0	0	67.91	0	0	11.6
2015	7	20	3	23	24	33		0	0	0	0	0	0	67.89	0	0	11.6
2015	7	20	3	33	24	33		0	0	0	0	0	0	67.87	0	0	11.6
2015	7	20	3	43	24	32		0	0	0	0	0	0	67.86	0	0	11.6
2015	7	20	3	53	24	32		0	0	0	0	0	0	67.84	0	0	11.6
2015	7	20	4	3	24	32		0	0	0	0	0	0	67.84	0	0	11.6
2015	7	20	4	13	24	33		0	0	0	0	0	0	67.82	0	0	11.6
2015	7	20	4	23	24	32		0	0	0	0	0	0	67.8	0	0	11.6
2015	7	20	4	33	24	33		0	0	0	0	0	0	67.8	0	0	11.6
2015	7	20	4	43	24	32		0	0	0	0	0	0	67.8	0	0	11.6
2015	7	20	4	53	24	32		0	0	0	0	0	0	67.77	0	0	11.6
2015	7	20	5	3	24	32		0	0	0	0	0	0	67.77	0	0	11.6
2015	7	20	5	13	24	33		0	0	0	0	0	0	67.77	0	0	11.6
2015	7	20	5	23	24	32		0	0	0	0	0	0	67.75	0	0	11.6
2015	7	20	5	33	24	31		0	0	0	0	0	0	67.73	0	0	11.6
2015	7	20	5	43	24	33		0	0	0	0	0	0	67.73	0	0	11.6
2015	7	20	5	53	24	33		0	0	0	0	0	0	67.71	0	0	11.6
2015	7	20	6	3	24	32		0	0	0	0	0	0	67.71	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	20	6	13	24	32		0	0	0	0	0	0	67.68	0	0	11.6
2015	7	20	6	23	24	32		0	0	0	0	0	0	67.66	0	0	11.6
2015	7	20	6	33	24	32		0	0	0	0	0	0	67.66	0	0	11.6
2015	7	20	6	43	24	32		0	0	0	0	0	0	67.64	0	0	11.6
2015	7	20	6	53	24	33		0	0	0	0	0	0	67.62	0	0	11.6
2015	7	20	7	3	24	32		0	0	0	0	0	0	67.62	0	0	11.6
2015	7	20	7	13	24	32		0	0	0	0	0	0	67.6	0	0	11.6
2015	7	20	7	23	24	31		0	0	0	0	0	0	67.6	0	0	11.6
2015	7	20	7	33	24	32		0	0	0	0	0	0	67.59	0	0	11.6
2015	7	20	7	43	24	32		0	0	0	0	0	0	67.59	0	0	11.6
2015	7	20	7	53	24	33		0	0	0	0	0	0	67.57	0	0	11.6
2015	7	20	8	3	24	33		0	0	0	0	0	0	67.55	0	0	11.6
2015	7	20	8	13	24	33		0	0	0	0	0	0	67.53	0	0	11.6
2015	7	20	8	23	24	33		0	0	0	0	0	0	67.53	0	0	11.6
2015	7	20	8	33	24	33		0	0	0	0	0	0	67.51	0	0	11.6
2015	7	20	8	43	24	33		0	0	0	0	0	0	67.5	0	0	11.6
2015	7	20	8	53	24	32		0	0	0	0	0	0	67.5	0	0	11.6
2015	7	20	9	3	24	32		0	0	0	0	0	0	67.48	0	0	11.6
2015	7	20	9	13	24	33		0	0	0	0	0	0	67.5	0	0	11.8
2015	7	20	9	23	24	32		0	0	0	0	0	0	67.51	0	0	11.8
2015	7	20	9	33	24	32		0	0	0	0	0	0	67.5	0	0	11.8
2015	7	20	9	43	24	32		0	0	0	0	0	0	67.5	0	0	11.8
2015	7	20	9	53	24	32		0	0	0	0	0	0	67.48	0	0	11.8
2015	7	20	10	3	24	32		0	0	0	0	0	0	67.48	0	0	11.8
2015	7	20	10	13	24	33		0	0	0	0	0	0	67.5	0	0	11.8
2015	7	20	10	23	24	32		0	0	0	0	0	0	67.5	0	0	11.8
2015	7	20	10	33	24	33		0	0	0	0	0	0	67.53	0	0	12
2015	7	20	10	43	24	32		0	0	0	0	0	0	67.59	0	0	12.2
2015	7	20	10	53	24	32		0	0	0	0	0	0	67.64	0	0	12.4
2015	7	20	11	3	24	33		0	0	0	0	0	0	67.62	0	0	12
2015	7	20	11	13	24	33		0	0	0	0	0	0	67.64	0	0	12.2
2015	7	20	11	23	24	32		0	0	0	0	0	0	67.64	0	0	12.2
2015	7	20	11	33	24	32		0	0	0	0	0	0	67.73	0	0	12.4
2015	7	20	11	43	24	32		0	0	0	0	0	0	67.78	0	0	13
2015	7	20	11	53	24	32		0	0	0	0	0	0	67.84	0	0	13.4
2015	7	20	12	3	24	32		0	0	0	0	0	0	67.8	0	0	13
2015	7	20	12	13	24	33		0	0	0	0	0	0	67.8	0	0	13.2
2015	7	20	12	23	24	32		0	0	0	0	0	0	67.84	0	0	13.6
2015	7	20	12	33	24	33		0	0	0	0	0	0	67.84	0	0	13
2015	7	20	12	43	24	32		0	0	0	0	0	0	67.86	0	0	13
2015	7	20	12	53	24	33		0	0	0	0	0	0	67.87	0	0	13.2
2015	7	20	13	3	24	32		0	0	0	0	0	0	67.91	0	0	13.2
2015	7	20	13	13	24	32		0	0	0	0	0	0	67.96	0	0	13.6
2015	7	20	13	23	24	33		0	0	0	0	0	0	68	0	0	13.4
2015	7	20	13	33	24	33		0	0	0	0	0	0	68.05	0	0	13.6
2015	7	20	13	43	24	33		0	0	0	0	0	0	68.07	0	0	12.8
2015	7	20	13	53	24	32		0	0	0	0	0	0	68.07	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	20	14	3	24	32		0	0	0	0	0	0	68.11	0	0	12.6
2015	7	20	14	13	24	33		0	0	0	0	0	0	68.11	0	0	12.4
2015	7	20	14	23	24	33		0	0	0	0	0	0	68.13	0	0	12.4
2015	7	20	14	33	24	32		0	0	0	0	0	0	68.14	0	0	12.2
2015	7	20	14	43	24	32		0	0	0	0	0	0	68.16	0	0	12.2
2015	7	20	14	53	24	33		0	0	0	0	0	0	68.2	0	0	12.2
2015	7	20	15	3	24	32		0	0	0	0	0	0	68.22	0	0	12.2
2015	7	20	15	13	24	32		0	0	0	0	0	0	68.23	0	0	12.4
2015	7	20	15	23	24	32		0	0	0	0	0	0	68.29	0	0	12.8
2015	7	20	15	33	24	32		0	0	0	0	0	0	68.36	0	0	12.8
2015	7	20	15	43	24	33		0	0	0	0	0	0	68.41	0	0	13
2015	7	20	15	53	24	33		0	0	0	0	0	0	68.45	0	0	13
2015	7	20	16	3	24	32		0	0	0	0	0	0	68.47	0	0	13
2015	7	20	16	13	24	33		0	0	0	0	0	0	68.52	0	0	12.8
2015	7	20	16	23	24	32		0	0	0	0	0	0	68.54	0	0	12.8
2015	7	20	16	33	24	32		0	0	0	0	0	0	68.56	0	0	13.2
2015	7	20	16	43	24	32		0	0	0	0	0	0	68.58	0	0	13.2
2015	7	20	16	53	24	32		0	0	0	0	0	0	68.61	0	0	13.4
2015	7	20	17	3	24	33		0	0	0	0	0	0	68.63	0	0	13
2015	7	20	17	13	24	33		0	0	0	0	0	0	68.63	0	0	12.6
2015	7	20	17	23	24	33		0	0	0	0	0	0	68.65	0	0	12.6
2015	7	20	17	33	24	33		0	0	0	0	0	0	68.67	0	0	12.2
2015	7	20	17	43	24	32		0	0	0	0	0	0	68.68	0	0	12.2
2015	7	20	17	53	24	33		0	0	0	0	0	0	68.68	0	0	12
2015	7	20	18	3	24	32		0	0	0	0	0	0	68.68	0	0	12
2015	7	20	18	13	24	33		0	0	0	0	0	0	68.68	0	0	11.8
2015	7	20	18	23	24	32		0	0	0	0	0	0	68.7	0	0	11.8
2015	7	20	18	33	24	32		0	0	0	0	0	0	68.7	0	0	11.8
2015	7	20	18	43	24	32		0	0	0	0	0	0	68.7	0	0	11.8
2015	7	20	18	53	24	32		0	0	0	0	0	0	68.7	0	0	11.8
2015	7	20	19	3	24	32		0	0	0	0	0	0	68.7	0	0	11.8
2015	7	20	19	13	24	33		0	0	0	0	0	0	68.7	0	0	11.8
2015	7	20	19	23	24	32		0	0	0	0	0	0	68.7	0	0	11.8
2015	7	20	19	33	24	32		0	0	0	0	0	0	68.7	0	0	11.8
2015	7	20	19	43	24	33		0	0	0	0	0	0	68.72	0	0	11.8
2015	7	20	19	53	24	33		0	0	0	0	0	0	68.7	0	0	11.8
2015	7	20	20	3	24	33		0	0	0	0	0	0	68.7	0	0	11.8
2015	7	20	20	13	24	32		0	0	0	0	0	0	68.72	0	0	11.8
2015	7	20	20	23	24	32		0	0	0	0	0	0	68.7	0	0	11.8
2015	7	20	20	33	24	33		0	0	0	0	0	0	68.7	0	0	11.8
2015	7	20	20	43	24	33		0	0	0	0	0	0	68.68	0	0	11.8
2015	7	20	20	53	24	32		0	0	0	0	0	0	68.68	0	0	11.8
2015	7	20	21	3	24	32		0	0	0	0	0	0	68.67	0	0	11.8
2015	7	20	21	13	24	33		0	0	0	0	0	0	68.67	0	0	11.8
2015	7	20	21	23	24	32		0	0	0	0	0	0	68.65	0	0	11.8
2015	7	20	21	33	24	32		0	0	0	0	0	0	68.63	0	0	11.8
2015	7	20	21	43	24	32		0	0	0	0	0	0	68.61	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	20	21	53	24	32		0	0	0	0	0	0	68.59	0	0	11.8
2015	7	20	22	3	24	33		0	0	0	0	0	0	68.59	0	0	11.8
2015	7	20	22	13	24	32		0	0	0	0	0	0	68.58	0	0	11.8
2015	7	20	22	23	24	32		0	0	0	0	0	0	68.56	0	0	11.8
2015	7	20	22	33	24	33		0	0	0	0	0	0	68.54	0	0	11.8
2015	7	20	22	43	24	32		0	0	0	0	0	0	68.52	0	0	11.8
2015	7	20	22	53	24	32		0	0	0	0	0	0	68.5	0	0	11.8
2015	7	20	23	3	24	32		0	0	0	0	0	0	68.49	0	0	11.8
2015	7	20	23	13	24	32		0	0	0	0	0	0	68.47	0	0	11.8
2015	7	20	23	23	24	32		0	0	0	0	0	0	68.45	0	0	11.8
2015	7	20	23	33	24	32		0	0	0	0	0	0	68.43	0	0	11.8
2015	7	20	23	43	24	33		0	0	0	0	0	0	68.41	0	0	11.8
2015	7	20	23	53	24	32		0	0	0	0	0	0	68.38	0	0	11.8
2015	7	21	0	3	24	32		0	0	0	0	0	0	68.36	0	0	11.8
2015	7	21	0	13	24	32		0	0	0	0	0	0	68.32	0	0	11.8
2015	7	21	0	23	24	32		0	0	0	0	0	0	68.31	0	0	11.8
2015	7	21	0	33	24	32		0	0	0	0	0	0	68.29	0	0	11.8
2015	7	21	0	43	24	32		0	0	0	0	0	0	68.25	0	0	11.8
2015	7	21	0	53	24	32		0	0	0	0	0	0	68.23	0	0	11.8
2015	7	21	1	3	24	32		0	0	0	0	0	0	68.22	0	0	11.8
2015	7	21	1	13	24	33		0	0	0	0	0	0	68.2	0	0	11.8
2015	7	21	1	23	24	32		0	0	0	0	0	0	68.18	0	0	11.8
2015	7	21	1	33	24	32		0	0	0	0	0	0	68.16	0	0	11.6
2015	7	21	1	43	24	33		0	0	0	0	0	0	68.14	0	0	11.6
2015	7	21	1	53	24	33		0	0	0	0	0	0	68.13	0	0	11.6
2015	7	21	2	3	24	32		0	0	0	0	0	0	68.11	0	0	11.6
2015	7	21	2	13	24	33		0	0	0	0	0	0	68.07	0	0	11.6
2015	7	21	2	23	24	32		0	0	0	0	0	0	68.05	0	0	11.6
2015	7	21	2	33	24	32		0	0	0	0	0	0	68.04	0	0	11.6
2015	7	21	2	43	24	32		0	0	0	0	0	0	68	0	0	11.6
2015	7	21	2	53	24	32		0	0	0	0	0	0	67.98	0	0	11.6
2015	7	21	3	3	24	32		0	0	0	0	0	0	67.96	0	0	11.6
2015	7	21	3	13	24	32		0	0	0	0	0	0	67.95	0	0	11.6
2015	7	21	3	23	24	33		0	0	0	0	0	0	67.91	0	0	11.6
2015	7	21	3	33	24	32		0	0	0	0	0	0	67.89	0	0	11.6
2015	7	21	3	43	24	32		0	0	0	0	0	0	67.87	0	0	11.6
2015	7	21	3	53	24	33		0	0	0	0	0	0	67.86	0	0	11.6
2015	7	21	4	3	24	33		0	0	0	0	0	0	67.82	0	0	11.6
2015	7	21	4	13	24	32		0	0	0	0	0	0	67.8	0	0	11.6
2015	7	21	4	23	24	32		0	0	0	0	0	0	67.78	0	0	11.6
2015	7	21	4	33	24	32		0	0	0	0	0	0	67.75	0	0	11.6
2015	7	21	4	43	24	32		0	0	0	0	0	0	67.73	0	0	11.6
2015	7	21	4	53	24	32		0	0	0	0	0	0	67.69	0	0	11.6
2015	7	21	5	3	24	32		0	0	0	0	0	0	67.68	0	0	11.6
2015	7	21	5	13	24	33		0	0	0	0	0	0	67.66	0	0	11.6
2015	7	21	5	23	24	33		0	0	0	0	0	0	67.62	0	0	11.6
2015	7	21	5	33	24	33		0	0	0	0	0	0	67.6	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	21	5	43	24	33		0	0	0	0	0	0	67.59	0	0	11.6
2015	7	21	5	53	24	32		0	0	0	0	0	0	67.55	0	0	11.6
2015	7	21	6	3	24	32		0	0	0	0	0	0	67.53	0	0	11.6
2015	7	21	6	13	24	33		0	0	0	0	0	0	67.5	0	0	11.6
2015	7	21	6	23	24	32		0	0	0	0	0	0	67.48	0	0	11.6
2015	7	21	6	33	24	33		0	0	0	0	0	0	67.46	0	0	11.6
2015	7	21	6	43	24	32		0	0	0	0	0	0	67.42	0	0	11.6
2015	7	21	6	53	24	33		0	0	0	0	0	0	67.41	0	0	11.6
2015	7	21	7	3	24	32		0	0	0	0	0	0	67.39	0	0	11.8
2015	7	21	7	13	24	31		0	0	0	0	0	0	67.37	0	0	11.8
2015	7	21	7	23	24	32		0	0	0	0	0	0	67.33	0	0	11.8
2015	7	21	7	33	24	32		0	0	0	0	0	0	67.33	0	0	11.8
2015	7	21	7	43	24	33		0	0	0	0	0	0	67.33	0	0	11.8
2015	7	21	7	53	24	32		0	0	0	0	0	0	67.33	0	0	11.8
2015	7	21	8	3	24	33		0	0	0	0	0	0	67.33	0	0	11.8
2015	7	21	8	13	24	32		0	0	0	0	0	0	67.33	0	0	12
2015	7	21	8	23	24	32		0	0	0	0	0	0	67.35	0	0	12
2015	7	21	8	33	24	32		0	0	0	0	0	0	67.35	0	0	12
2015	7	21	8	43	24	32		0	0	0	0	0	0	67.39	0	0	12
2015	7	21	8	53	24	32		0	0	0	0	0	0	67.39	0	0	12
2015	7	21	9	3	24	32		0	0	0	0	0	0	67.41	0	0	12.2
2015	7	21	9	13	24	32		0	0	0	0	0	0	67.42	0	0	12.2
2015	7	21	9	23	24	33		0	0	0	0	0	0	67.46	0	0	12.8
2015	7	21	9	33	24	32		0	0	0	0	0	0	67.5	0	0	12.6
2015	7	21	9	43	24	33		0	0	0	0	0	0	67.48	0	0	13
2015	7	21	9	53	24	33		0	0	0	0	0	0	67.51	0	0	13
2015	7	21	10	3	24	32		0	0	0	0	0	0	67.59	0	0	12.6
2015	7	21	10	13	24	33		0	0	0	0	0	0	67.6	0	0	13
2015	7	21	10	23	24	32		0	0	0	0	0	0	67.68	0	0	12.6
2015	7	21	10	33	24	32		0	0	0	0	0	0	67.73	0	0	13.2
2015	7	21	10	43	24	33		0	0	0	0	0	0	67.78	0	0	12.6
2015	7	21	10	53	24	31		0	0	0	0	0	0	67.84	0	0	12.6
2015	7	21	11	3	24	32		0	0	0	0	0	0	67.89	0	0	12.6
2015	7	21	11	13	24	32		0	0	0	0	0	0	67.95	0	0	12.6
2015	7	21	11	23	24	32		0	0	0	0	0	0	68	0	0	12.6
2015	7	21	11	33	24	32		0	0	0	0	0	0	68.07	0	0	12.4
2015	7	21	11	43	24	33		0	0	0	0	0	0	68.14	0	0	13
2015	7	21	11	53	24	32		0	0	0	0	0	0	68.18	0	0	13.4
2015	7	21	12	3	24	33		0	0	0	0	0	0	68.25	0	0	13.2
2015	7	21	12	13	24	32		0	0	0	0	0	0	68.32	0	0	12.8
2015	7	21	12	23	24	32		0	0	0	0	0	0	68.38	0	0	13
2015	7	21	12	33	24	32		0	0	0	0	0	0	68.45	0	0	13
2015	7	21	12	43	24	33		0	0	0	0	0	0	68.52	0	0	12.8
2015	7	21	12	53	24	32		0	0	0	0	0	0	68.58	0	0	13
2015	7	21	13	3	24	33		0	0	0	0	0	0	68.65	0	0	12.8
2015	7	21	13	13	24	33		0	0	0	0	0	0	68.72	0	0	12.8
2015	7	21	13	23	24	33		0	0	0	0	0	0	68.77	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	21	13	33	24	32		0	0	0	0	0	0	68.85	0	0	13.2
2015	7	21	13	43	24	33		0	0	0	0	0	0	68.9	0	0	13
2015	7	21	13	53	24	32		0	0	0	0	0	0	68.97	0	0	13
2015	7	21	14	3	24	32		0	0	0	0	0	0	69.03	0	0	13
2015	7	21	14	13	24	33		0	0	0	0	0	0	69.08	0	0	13
2015	7	21	14	23	24	33		0	0	0	0	0	0	69.13	0	0	13
2015	7	21	14	33	24	31		0	0	0	0	0	0	69.19	0	0	13.2
2015	7	21	14	43	24	32		0	0	0	0	0	0	69.24	0	0	13
2015	7	21	14	53	24	33		0	0	0	0	0	0	69.3	0	0	13
2015	7	21	15	3	24	32		0	0	0	0	0	0	69.33	0	0	12.8
2015	7	21	15	13	24	33		0	0	0	0	0	0	69.37	0	0	12.8
2015	7	21	15	23	24	32		0	0	0	0	0	0	69.42	0	0	12.8
2015	7	21	15	33	24	32		0	0	0	0	0	0	69.46	0	0	13
2015	7	21	15	43	24	32		0	0	0	0	0	0	69.49	0	0	12.8
2015	7	21	15	53	24	33		0	0	0	0	0	0	69.51	0	0	12.8
2015	7	21	16	3	24	32		0	0	0	0	0	0	69.53	0	0	12.6
2015	7	21	16	13	24	32		0	0	0	0	0	0	69.53	0	0	12.6
2015	7	21	16	23	24	32		0	0	0	0	0	0	69.53	0	0	12.2
2015	7	21	16	33	24	32		0	0	0	0	0	0	69.51	0	0	12
2015	7	21	16	43	24	32		0	0	0	0	0	0	69.51	0	0	12.2
2015	7	21	16	53	24	32		0	0	0	0	0	0	69.53	0	0	12
2015	7	21	17	3	24	33		0	0	0	0	0	0	69.53	0	0	12
2015	7	21	17	13	24	32		0	0	0	0	0	0	69.55	0	0	12
2015	7	21	17	23	24	32		0	0	0	0	0	0	69.57	0	0	12.2
2015	7	21	17	33	24	31		0	0	0	0	0	0	69.58	0	0	12
2015	7	21	17	43	24	31		0	0	0	0	0	0	69.6	0	0	12
2015	7	21	17	53	24	32		0	0	0	0	0	0	69.6	0	0	12
2015	7	21	18	3	24	32		0	0	0	0	0	0	69.6	0	0	12
2015	7	21	18	13	24	32		0	0	0	0	0	0	69.6	0	0	12
2015	7	21	18	23	24	32		0	0	0	0	0	0	69.6	0	0	11.8
2015	7	21	18	33	24	32		0	0	0	0	0	0	69.6	0	0	11.8
2015	7	21	18	43	24	33		0	0	0	0	0	0	69.6	0	0	11.8
2015	7	21	18	53	24	32		0	0	0	0	0	0	69.6	0	0	11.6
2015	7	21	19	3	24	33		0	0	0	0	0	0	69.58	0	0	11.6
2015	7	21	19	13	24	31		0	0	0	0	0	0	69.57	0	0	11.6
2015	7	21	19	23	24	32		0	0	0	0	0	0	69.57	0	0	11.4
2015	7	21	19	33	24	33		0	0	0	0	0	0	69.57	0	0	11.8
2015	7	21	19	43	24	32		0	0	0	0	0	0	69.55	0	0	11.6
2015	7	21	19	53	24	32		0	0	0	0	0	0	69.55	0	0	11.4
2015	7	21	20	3	24	31		0	0	0	0	0	0	69.55	0	0	11.4
2015	7	21	20	13	24	33		0	0	0	0	0	0	69.53	0	0	11.4
2015	7	21	20	23	24	33		0	0	0	0	0	0	69.51	0	0	11.4
2015	7	21	20	33	24	32		0	0	0	0	0	0	69.49	0	0	11.8
2015	7	21	20	43	24	32		0	0	0	0	0	0	69.49	0	0	11.8
2015	7	21	20	53	24	32		0	0	0	0	0	0	69.48	0	0	11.8
2015	7	21	21	3	24	32		0	0	0	0	0	0	69.48	0	0	11.8
2015	7	21	21	13	24	32		0	0	0	0	0	0	69.46	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	21	21	23	24	33		0	0	0	0	0	0	69.44	0	0	11.8
2015	7	21	21	33	24	32		0	0	0	0	0	0	69.42	0	0	11.8
2015	7	21	21	43	24	32		0	0	0	0	0	0	69.4	0	0	11.8
2015	7	21	21	53	24	32		0	0	0	0	0	0	69.39	0	0	11.8
2015	7	21	22	3	24	32		0	0	0	0	0	0	69.37	0	0	11.8
2015	7	21	22	13	24	32		0	0	0	0	0	0	69.33	0	0	11.8
2015	7	21	22	23	24	32		0	0	0	0	0	0	69.31	0	0	11.8
2015	7	21	22	33	24	32		0	0	0	0	0	0	69.3	0	0	11.8
2015	7	21	22	43	24	32		0	0	0	0	0	0	69.28	0	0	11.8
2015	7	21	22	53	24	33		0	0	0	0	0	0	69.24	0	0	11.8
2015	7	21	23	3	24	31		0	0	0	0	0	0	69.22	0	0	11.8
2015	7	21	23	13	24	33		0	0	0	0	0	0	69.21	0	0	11.8
2015	7	21	23	23	24	32		0	0	0	0	0	0	69.17	0	0	11.8
2015	7	21	23	33	24	32		0	0	0	0	0	0	69.15	0	0	11.8
2015	7	21	23	43	24	33		0	0	0	0	0	0	69.12	0	0	11.8
2015	7	21	23	53	24	32		0	0	0	0	0	0	69.1	0	0	11.8
2015	7	22	0	3	24	32		0	0	0	0	0	0	69.06	0	0	11.8
2015	7	22	0	13	24	33		0	0	0	0	0	0	69.04	0	0	11.8
2015	7	22	0	23	24	32		0	0	0	0	0	0	69.01	0	0	11.8
2015	7	22	0	33	24	32		0	0	0	0	0	0	68.97	0	0	11.8
2015	7	22	0	43	24	33		0	0	0	0	0	0	68.95	0	0	11.8
2015	7	22	0	53	24	33		0	0	0	0	0	0	68.94	0	0	11.8
2015	7	22	1	3	24	32		0	0	0	0	0	0	68.92	0	0	11.8
2015	7	22	1	13	24	33		0	0	0	0	0	0	68.88	0	0	11.8
2015	7	22	1	23	24	32		0	0	0	0	0	0	68.86	0	0	11.8
2015	7	22	1	33	24	31		0	0	0	0	0	0	68.85	0	0	11.8
2015	7	22	1	43	24	32		0	0	0	0	0	0	68.79	0	0	11.8
2015	7	22	1	53	24	33		0	0	0	0	0	0	68.79	0	0	11.8
2015	7	22	2	3	24	32		0	0	0	0	0	0	68.74	0	0	11.8
2015	7	22	2	13	24	32		0	0	0	0	0	0	68.72	0	0	11.8
2015	7	22	2	23	24	32		0	0	0	0	0	0	68.68	0	0	11.8
2015	7	22	2	33	24	32		0	0	0	0	0	0	68.65	0	0	11.6
2015	7	22	2	43	24	32		0	0	0	0	0	0	68.63	0	0	11.6
2015	7	22	2	53	24	32		0	0	0	0	0	0	68.61	0	0	11.6
2015	7	22	3	3	24	33		0	0	0	0	0	0	68.58	0	0	11.6
2015	7	22	3	13	24	32		0	0	0	0	0	0	68.54	0	0	11.6
2015	7	22	3	23	24	33		0	0	0	0	0	0	68.5	0	0	11.6
2015	7	22	3	33	24	32		0	0	0	0	0	0	68.49	0	0	11.6
2015	7	22	3	43	24	32		0	0	0	0	0	0	68.45	0	0	11.6
2015	7	22	3	53	24	32		0	0	0	0	0	0	68.43	0	0	11.6
2015	7	22	4	3	24	32		0	0	0	0	0	0	68.38	0	0	11.6
2015	7	22	4	13	24	32		0	0	0	0	0	0	68.34	0	0	11.6
2015	7	22	4	23	24	32		0	0	0	0	0	0	68.31	0	0	11.6
2015	7	22	4	33	24	33		0	0	0	0	0	0	68.29	0	0	11.6
2015	7	22	4	43	24	32		0	0	0	0	0	0	68.25	0	0	11.6
2015	7	22	4	53	24	32		0	0	0	0	0	0	68.22	0	0	11.6
2015	7	22	5	3	24	32		0	0	0	0	0	0	68.18	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	22	5	13	24	33		0	0	0	0	0	0	68.13	0	0	11.6
2015	7	22	5	23	24	33		0	0	0	0	0	0	68.11	0	0	11.6
2015	7	22	5	33	24	33		0	0	0	0	0	0	68.05	0	0	11.6
2015	7	22	5	43	24	32		0	0	0	0	0	0	68.02	0	0	11.6
2015	7	22	5	53	24	33		0	0	0	0	0	0	67.98	0	0	11.6
2015	7	22	6	3	24	33		0	0	0	0	0	0	67.95	0	0	11.6
2015	7	22	6	13	24	32		0	0	0	0	0	0	67.91	0	0	11.6
2015	7	22	6	23	24	32		0	0	0	0	0	0	67.87	0	0	11.6
2015	7	22	6	33	24	32		0	0	0	0	0	0	67.84	0	0	11.6
2015	7	22	6	43	24	32		0	0	0	0	0	0	67.8	0	0	11.6
2015	7	22	6	53	24	31		0	0	0	0	0	0	67.78	0	0	11.6
2015	7	22	7	3	24	33		0	0	0	0	0	0	67.75	0	0	11.8
2015	7	22	7	13	24	32		0	0	0	0	0	0	67.71	0	0	11.8
2015	7	22	7	23	24	32		0	0	0	0	0	0	67.71	0	0	11.8
2015	7	22	7	33	24	33		0	0	0	0	0	0	67.68	0	0	11.8
2015	7	22	7	43	24	32		0	0	0	0	0	0	67.68	0	0	11.8
2015	7	22	7	53	24	32		0	0	0	0	0	0	67.68	0	0	12
2015	7	22	8	3	24	32		0	0	0	0	0	0	67.68	0	0	12
2015	7	22	8	13	24	33		0	0	0	0	0	0	67.68	0	0	12
2015	7	22	8	23	24	33		0	0	0	0	0	0	67.68	0	0	12.2
2015	7	22	8	33	24	33		0	0	0	0	0	0	67.71	0	0	12.2
2015	7	22	8	43	24	31		0	0	0	0	0	0	67.71	0	0	12.2
2015	7	22	8	53	24	32		0	0	0	0	0	0	67.73	0	0	13.2
2015	7	22	9	3	24	32		0	0	0	0	0	0	67.77	0	0	13.2
2015	7	22	9	13	24	32		0	0	0	0	0	0	67.78	0	0	13
2015	7	22	9	23	24	32		0	0	0	0	0	0	67.82	0	0	12.8
2015	7	22	9	33	24	32		0	0	0	0	0	0	67.86	0	0	12.6
2015	7	22	9	43	24	32		0	0	0	0	0	0	67.89	0	0	12.6
2015	7	22	9	53	24	32		0	0	0	0	0	0	67.95	0	0	12.6
2015	7	22	10	3	24	32		0	0	0	0	0	0	68	0	0	12.8
2015	7	22	10	13	24	32		0	0	0	0	0	0	68.04	0	0	12.8
2015	7	22	10	23	24	32		0	0	0	0	0	0	68.09	0	0	12.8
2015	7	22	10	33	24	33		0	0	0	0	0	0	68.13	0	0	13
2015	7	22	10	43	24	33		0	0	0	0	0	0	68.18	0	0	13
2015	7	22	10	53	24	32		0	0	0	0	0	0	68.22	0	0	13
2015	7	22	11	3	24	33		0	0	0	0	0	0	68.27	0	0	13
2015	7	22	11	13	24	33		0	0	0	0	0	0	68.32	0	0	13
2015	7	22	11	23	24	32		0	0	0	0	0	0	68.38	0	0	13
2015	7	22	11	33	24	33		0	0	0	0	0	0	68.43	0	0	13
2015	7	22	11	43	24	33		0	0	0	0	0	0	68.49	0	0	13
2015	7	22	11	53	24	32		0	0	0	0	0	0	68.56	0	0	13
2015	7	22	12	3	24	33		0	0	0	0	0	0	68.61	0	0	13
2015	7	22	12	13	24	32		0	0	0	0	0	0	68.67	0	0	13
2015	7	22	12	23	24	32		0	0	0	0	0	0	68.74	0	0	12.8
2015	7	22	12	33	24	32		0	0	0	0	0	0	68.79	0	0	13
2015	7	22	12	43	24	32		0	0	0	0	0	0	68.85	0	0	13
2015	7	22	12	53	24	32		0	0	0	0	0	0	68.9	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	22	13	3	24	32		0	0	0	0	0	0	68.95	0	0	13
2015	7	22	13	13	24	32		0	0	0	0	0	0	69.01	0	0	13
2015	7	22	13	23	24	32		0	0	0	0	0	0	69.06	0	0	13
2015	7	22	13	33	24	33		0	0	0	0	0	0	69.1	0	0	12.8
2015	7	22	13	43	24	31		0	0	0	0	0	0	68.92	0	0	12.4
2015	7	22	13	53	24	33		0	0	0	0	0	0	69.03	0	0	13.2
2015	7	22	14	3	24	32		0	0	0	0	0	0	69.08	0	0	13
2015	7	22	14	13	24	32		0	0	0	0	0	0	69.12	0	0	12.8
2015	7	22	14	23	24	32		0	0	0	0	0	0	69.22	0	0	12.8
2015	7	22	14	33	24	32		0	0	0	0	0	0	69.28	0	0	13.6
2015	7	22	14	43	24	32		0	0	0	0	0	0	69.33	0	0	13.2
2015	7	22	14	53	24	32		0	0	0	0	0	0	69.39	0	0	13
2015	7	22	15	3	24	33		0	0	0	0	0	0	69.42	0	0	13
2015	7	22	15	13	24	32		0	0	0	0	0	0	69.48	0	0	13.2
2015	7	22	15	23	24	32		0	0	0	0	0	0	69.53	0	0	13
2015	7	22	15	33	24	33		0	0	0	0	0	0	69.51	0	0	12.8
2015	7	22	15	43	24	33		0	0	0	0	0	0	69.42	0	0	12.6
2015	7	22	15	53	24	32		0	0	0	0	0	0	69.49	0	0	13.2
2015	7	22	16	3	24	32		0	0	0	0	0	0	69.51	0	0	12.8
2015	7	22	16	13	24	32		0	0	0	0	0	0	69.51	0	0	12.8
2015	7	22	16	23	24	32		0	0	0	0	0	0	69.49	0	0	12.4
2015	7	22	16	33	24	32		0	0	0	0	0	0	69.49	0	0	12.4
2015	7	22	16	43	24	32		0	0	0	0	0	0	69.53	0	0	12.2
2015	7	22	16	53	24	32		0	0	0	0	0	0	69.55	0	0	12.2
2015	7	22	17	3	24	31		0	0	0	0	0	0	69.49	0	0	12
2015	7	22	17	13	24	32		0	0	0	0	0	0	69.51	0	0	12
2015	7	22	17	23	24	33		0	0	0	0	0	0	69.51	0	0	12
2015	7	22	17	33	24	32		0	0	0	0	0	0	69.51	0	0	12
2015	7	22	17	43	24	32		0	0	0	0	0	0	69.49	0	0	12
2015	7	22	17	53	24	32		0	0	0	0	0	0	69.49	0	0	12
2015	7	22	18	3	24	32		0	0	0	0	0	0	69.49	0	0	12
2015	7	22	18	13	24	32		0	0	0	0	0	0	69.49	0	0	12
2015	7	22	18	23	24	32		0	0	0	0	0	0	69.49	0	0	12
2015	7	22	18	33	24	32		0	0	0	0	0	0	69.49	0	0	12
2015	7	22	18	43	24	32		0	0	0	0	0	0	69.48	0	0	11.8
2015	7	22	18	53	24	33		0	0	0	0	0	0	69.48	0	0	11.8
2015	7	22	19	3	24	32		0	0	0	0	0	0	69.48	0	0	11.8
2015	7	22	19	13	24	32		0	0	0	0	0	0	69.48	0	0	11.8
2015	7	22	19	23	24	33		0	0	0	0	0	0	69.46	0	0	11.8
2015	7	22	19	33	24	32		0	0	0	0	0	0	69.46	0	0	11.8
2015	7	22	19	43	24	32		0	0	0	0	0	0	69.46	0	0	11.8
2015	7	22	19	53	24	32		0	0	0	0	0	0	69.44	0	0	11.8
2015	7	22	20	3	24	32		0	0	0	0	0	0	69.44	0	0	11.8
2015	7	22	20	13	24	33		0	0	0	0	0	0	69.42	0	0	11.8
2015	7	22	20	23	24	32		0	0	0	0	0	0	69.4	0	0	11.8
2015	7	22	20	33	24	32		0	0	0	0	0	0	69.4	0	0	11.8
2015	7	22	20	43	24	32		0	0	0	0	0	0	69.4	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	22	20	53	24	32		0	0	0	0	0	0	69.39	0	0	11.8
2015	7	22	21	3	24	32		0	0	0	0	0	0	69.37	0	0	11.8
2015	7	22	21	13	24	33		0	0	0	0	0	0	69.35	0	0	11.8
2015	7	22	21	23	24	32		0	0	0	0	0	0	69.35	0	0	11.8
2015	7	22	21	33	24	32		0	0	0	0	0	0	69.33	0	0	11.8
2015	7	22	21	43	24	32		0	0	0	0	0	0	69.33	0	0	11.8
2015	7	22	21	53	24	32		0	0	0	0	0	0	69.31	0	0	11.8
2015	7	22	22	3	24	32		0	0	0	0	0	0	69.3	0	0	11.8
2015	7	22	22	13	24	33		0	0	0	0	0	0	69.28	0	0	11.8
2015	7	22	22	23	24	32		0	0	0	0	0	0	69.26	0	0	11.8
2015	7	22	22	33	24	32		0	0	0	0	0	0	69.24	0	0	11.8
2015	7	22	22	43	24	32		0	0	0	0	0	0	69.22	0	0	11.8
2015	7	22	22	53	24	32		0	0	0	0	0	0	69.22	0	0	11.8
2015	7	22	23	3	24	32		0	0	0	0	0	0	69.19	0	0	11.8
2015	7	22	23	13	24	32		0	0	0	0	0	0	69.19	0	0	11.8
2015	7	22	23	23	24	32		0	0	0	0	0	0	69.17	0	0	11.8
2015	7	22	23	33	24	31		0	0	0	0	0	0	69.15	0	0	11.8
2015	7	22	23	43	24	32		0	0	0	0	0	0	69.13	0	0	11.8
2015	7	22	23	53	24	32		0	0	0	0	0	0	69.12	0	0	11.8
2015	7	23	0	3	24	32		0	0	0	0	0	0	69.1	0	0	11.8
2015	7	23	0	13	24	32		0	0	0	0	0	0	69.06	0	0	11.8
2015	7	23	0	23	24	32		0	0	0	0	0	0	69.04	0	0	11.8
2015	7	23	0	33	24	32		0	0	0	0	0	0	69.03	0	0	11.8
2015	7	23	0	43	24	32		0	0	0	0	0	0	69.01	0	0	11.8
2015	7	23	0	53	24	33		0	0	0	0	0	0	68.99	0	0	11.8
2015	7	23	1	3	24	32		0	0	0	0	0	0	68.97	0	0	11.8
2015	7	23	1	13	24	33		0	0	0	0	0	0	68.95	0	0	11.8
2015	7	23	1	23	24	32		0	0	0	0	0	0	68.92	0	0	11.8
2015	7	23	1	33	24	32		0	0	0	0	0	0	68.9	0	0	11.8
2015	7	23	1	43	24	32		0	0	0	0	0	0	68.88	0	0	11.8
2015	7	23	1	53	24	31		0	0	0	0	0	0	68.86	0	0	11.8
2015	7	23	2	3	24	32		0	0	0	0	0	0	68.83	0	0	11.8
2015	7	23	2	13	24	33		0	0	0	0	0	0	68.81	0	0	11.6
2015	7	23	2	23	24	32		0	0	0	0	0	0	68.79	0	0	11.6
2015	7	23	2	33	24	31		0	0	0	0	0	0	68.76	0	0	11.6
2015	7	23	2	43	24	32		0	0	0	0	0	0	68.74	0	0	11.6
2015	7	23	2	53	24	31		0	0	0	0	0	0	68.7	0	0	11.6
2015	7	23	3	3	24	32		0	0	0	0	0	0	68.67	0	0	11.6
2015	7	23	3	13	24	32		0	0	0	0	0	0	68.65	0	0	11.6
2015	7	23	3	23	24	32		0	0	0	0	0	0	68.61	0	0	11.6
2015	7	23	3	33	24	33		0	0	0	0	0	0	68.58	0	0	11.6
2015	7	23	3	43	24	33		0	0	0	0	0	0	68.54	0	0	11.6
2015	7	23	3	53	24	32		0	0	0	0	0	0	68.5	0	0	11.6
2015	7	23	4	3	24	32		0	0	0	0	0	0	68.49	0	0	11.6
2015	7	23	4	13	24	32		0	0	0	0	0	0	68.45	0	0	11.6
2015	7	23	4	23	24	32		0	0	0	0	0	0	68.41	0	0	11.6
2015	7	23	4	33	24	32		0	0	0	0	0	0	68.38	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	23	4	43	24	32		0	0	0	0	0	0	68.36	0	0	11.6
2015	7	23	4	53	24	32		0	0	0	0	0	0	68.32	0	0	11.6
2015	7	23	5	3	24	32		0	0	0	0	0	0	68.29	0	0	11.6
2015	7	23	5	13	24	32		0	0	0	0	0	0	68.25	0	0	11.6
2015	7	23	5	23	24	32		0	0	0	0	0	0	68.23	0	0	11.6
2015	7	23	5	33	24	33		0	0	0	0	0	0	68.2	0	0	11.6
2015	7	23	5	43	24	32		0	0	0	0	0	0	68.16	0	0	11.6
2015	7	23	5	53	24	33		0	0	0	0	0	0	68.13	0	0	11.6
2015	7	23	6	3	24	33		0	0	0	0	0	0	68.11	0	0	11.6
2015	7	23	6	13	24	32		0	0	0	0	0	0	68.07	0	0	11.6
2015	7	23	6	23	24	32		0	0	0	0	0	0	68.04	0	0	11.6
2015	7	23	6	33	24	33		0	0	0	0	0	0	68.02	0	0	11.6
2015	7	23	6	43	24	32		0	0	0	0	0	0	67.98	0	0	11.6
2015	7	23	6	53	24	32		0	0	0	0	0	0	67.95	0	0	11.6
2015	7	23	7	3	24	32		0	0	0	0	0	0	67.93	0	0	11.8
2015	7	23	7	13	24	33		0	0	0	0	0	0	67.89	0	0	11.8
2015	7	23	7	23	24	32		0	0	0	0	0	0	67.91	0	0	11.8
2015	7	23	7	33	24	32		0	0	0	0	0	0	67.89	0	0	11.8
2015	7	23	7	43	24	32		0	0	0	0	0	0	67.89	0	0	11.8
2015	7	23	7	53	24	32		0	0	0	0	0	0	67.89	0	0	12
2015	7	23	8	3	24	32		0	0	0	0	0	0	67.89	0	0	12
2015	7	23	8	13	24	33		0	0	0	0	0	0	67.91	0	0	12
2015	7	23	8	23	24	33		0	0	0	0	0	0	67.93	0	0	12.2
2015	7	23	8	33	24	32		0	0	0	0	0	0	67.93	0	0	12.2
2015	7	23	8	43	24	32		0	0	0	0	0	0	67.95	0	0	12.4
2015	7	23	8	53	24	32		0	0	0	0	0	0	67.96	0	0	12.4
2015	7	23	9	3	24	33		0	0	0	0	0	0	68	0	0	12.6
2015	7	23	9	13	24	33		0	0	0	0	0	0	68.04	0	0	12.6
2015	7	23	9	23	24	32		0	0	0	0	0	0	68.05	0	0	12.6
2015	7	23	9	33	24	32		0	0	0	0	0	0	68.09	0	0	13.2
2015	7	23	9	43	24	33		0	0	0	0	0	0	68.13	0	0	13.2
2015	7	23	9	53	24	32		0	0	0	0	0	0	68.18	0	0	13
2015	7	23	10	3	24	32		0	0	0	0	0	0	68.22	0	0	13
2015	7	23	10	13	24	32		0	0	0	0	0	0	68.27	0	0	13
2015	7	23	10	23	24	32		0	0	0	0	0	0	68.32	0	0	13
2015	7	23	10	33	24	32		0	0	0	0	0	0	68.36	0	0	12.8
2015	7	23	10	43	24	32		0	0	0	0	0	0	68.41	0	0	12.8
2015	7	23	10	53	24	32		0	0	0	0	0	0	68.47	0	0	12.6
2015	7	23	11	3	24	32		0	0	0	0	0	0	68.54	0	0	12.6
2015	7	23	11	13	24	32		0	0	0	0	0	0	68.59	0	0	12.6
2015	7	23	11	23	24	32		0	0	0	0	0	0	68.65	0	0	12.6
2015	7	23	11	33	24	32		0	0	0	0	0	0	68.7	0	0	13.2
2015	7	23	11	43	24	33		0	0	0	0	0	0	68.76	0	0	13.2
2015	7	23	11	53	24	33		0	0	0	0	0	0	68.79	0	0	13.2
2015	7	23	12	3	24	33		0	0	0	0	0	0	68.86	0	0	13.2
2015	7	23	12	13	24	32		0	0	0	0	0	0	68.92	0	0	13.2
2015	7	23	12	23	24	32		0	0	0	0	0	0	68.99	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	23	12	33	24	32		0	0	0	0	0	0	69.04	0	0	14.2
2015	7	23	12	43	24	31		0	0	0	0	0	0	69.08	0	0	13.4
2015	7	23	12	53	24	33		0	0	0	0	0	0	69.17	0	0	13
2015	7	23	13	3	24	32		0	0	0	0	0	0	69.26	0	0	13
2015	7	23	13	13	24	32		0	0	0	0	0	0	69.31	0	0	13
2015	7	23	13	23	24	33		0	0	0	0	0	0	69.37	0	0	12.8
2015	7	23	13	33	24	32		0	0	0	0	0	0	69.4	0	0	13
2015	7	23	13	43	24	33		0	0	0	0	0	0	69.48	0	0	13
2015	7	23	13	53	24	32		0	0	0	0	0	0	69.51	0	0	12.8
2015	7	23	14	3	24	32		0	0	0	0	0	0	69.57	0	0	12.8
2015	7	23	14	13	24	32		0	0	0	0	0	0	69.6	0	0	13
2015	7	23	14	23	24	32		0	0	0	0	0	0	69.67	0	0	12.8
2015	7	23	14	33	24	32		0	0	0	0	0	0	69.69	0	0	12.8
2015	7	23	14	43	24	32		0	0	0	0	0	0	69.73	0	0	12.8
2015	7	23	14	53	24	32		0	0	0	0	0	0	69.78	0	0	12.8
2015	7	23	15	3	24	31		0	0	0	0	0	0	69.8	0	0	12.8
2015	7	23	15	13	24	32		0	0	0	0	0	0	69.84	0	0	12.8
2015	7	23	15	23	24	33		0	0	0	0	0	0	69.84	0	0	12.8
2015	7	23	15	33	24	32		0	0	0	0	0	0	69.87	0	0	12.8
2015	7	23	15	43	24	32		0	0	0	0	0	0	69.89	0	0	12.6
2015	7	23	15	53	24	32		0	0	0	0	0	0	69.91	0	0	12.6
2015	7	23	16	3	24	32		0	0	0	0	0	0	69.93	0	0	12.6
2015	7	23	16	13	24	32		0	0	0	0	0	0	69.94	0	0	12.6
2015	7	23	16	23	24	32		0	0	0	0	0	0	69.94	0	0	12.6
2015	7	23	16	33	24	33		0	0	0	0	0	0	69.94	0	0	12.6
2015	7	23	16	43	24	31		0	0	0	0	0	0	69.96	0	0	12.4
2015	7	23	16	53	24	32		0	0	0	0	0	0	69.96	0	0	12.4
2015	7	23	17	3	24	32		0	0	0	0	0	0	69.96	0	0	12.4
2015	7	23	17	13	24	32		0	0	0	0	0	0	69.96	0	0	12.2
2015	7	23	17	23	24	32		0	0	0	0	0	0	69.96	0	0	12.2
2015	7	23	17	33	24	32		0	0	0	0	0	0	69.94	0	0	12
2015	7	23	17	43	24	32		0	0	0	0	0	0	69.94	0	0	12
2015	7	23	17	53	24	33		0	0	0	0	0	0	69.91	0	0	11.8
2015	7	23	18	3	24	32		0	0	0	0	0	0	69.91	0	0	11.8
2015	7	23	18	13	24	32		0	0	0	0	0	0	69.89	0	0	11.6
2015	7	23	18	23	24	32		0	0	0	0	0	0	69.91	0	0	11.6
2015	7	23	18	33	24	32		0	0	0	0	0	0	69.89	0	0	11.6
2015	7	23	18	43	24	32		0	0	0	0	0	0	69.89	0	0	11.6
2015	7	23	18	53	24	32		0	0	0	0	0	0	69.87	0	0	11.4
2015	7	23	19	3	24	33		0	0	0	0	0	0	69.87	0	0	11.4
2015	7	23	19	13	24	32		0	0	0	0	0	0	69.87	0	0	11.4
2015	7	23	19	23	24	32		0	0	0	0	0	0	69.85	0	0	11.4
2015	7	23	19	33	24	32		0	0	0	0	0	0	69.85	0	0	11.4
2015	7	23	19	43	24	32		0	0	0	0	0	0	69.85	0	0	11.2
2015	7	23	19	53	24	33		0	0	0	0	0	0	69.84	0	0	11.2
2015	7	23	20	3	24	33		0	0	0	0	0	0	69.82	0	0	11.2
2015	7	23	20	13	24	32		0	0	0	0	0	0	69.82	0	0	11.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	23	20	23	24	32		0	0	0	0	0	0	69.8	0	0	11.2
2015	7	23	20	33	24	31		0	0	0	0	0	0	69.8	0	0	11.2
2015	7	23	20	43	24	32		0	0	0	0	0	0	69.76	0	0	11.2
2015	7	23	20	53	24	32		0	0	0	0	0	0	69.75	0	0	11.2
2015	7	23	21	3	24	32		0	0	0	0	0	0	69.73	0	0	11.2
2015	7	23	21	13	24	32		0	0	0	0	0	0	69.73	0	0	11
2015	7	23	21	23	24	32		0	0	0	0	0	0	69.69	0	0	11
2015	7	23	21	33	24	32		0	0	0	0	0	0	69.67	0	0	11.8
2015	7	23	21	43	24	32		0	0	0	0	0	0	69.64	0	0	11.8
2015	7	23	21	53	24	32		0	0	0	0	0	0	69.64	0	0	11.8
2015	7	23	22	3	24	32		0	0	0	0	0	0	69.6	0	0	11.8
2015	7	23	22	13	24	32		0	0	0	0	0	0	69.57	0	0	11.8
2015	7	23	22	23	24	32		0	0	0	0	0	0	69.57	0	0	11.8
2015	7	23	22	33	24	33		0	0	0	0	0	0	69.53	0	0	11.8
2015	7	23	22	43	24	32		0	0	0	0	0	0	69.53	0	0	11.8
2015	7	23	22	53	24	32		0	0	0	0	0	0	69.49	0	0	11.8
2015	7	23	23	3	24	32		0	0	0	0	0	0	69.46	0	0	11.8
2015	7	23	23	13	24	32		0	0	0	0	0	0	69.44	0	0	11.8
2015	7	23	23	23	24	32		0	0	0	0	0	0	69.4	0	0	11.8
2015	7	23	23	33	24	32		0	0	0	0	0	0	69.37	0	0	11
2015	7	23	23	43	24	32		0	0	0	0	0	0	69.35	0	0	11
2015	7	23	23	53	24	32		0	0	0	0	0	0	69.31	0	0	11
2015	7	24	0	3	24	33		0	0	0	0	0	0	69.28	0	0	10.8
2015	7	24	0	13	24	33		0	0	0	0	0	0	69.24	0	0	10.8
2015	7	24	0	23	24	33		0	0	0	0	0	0	69.22	0	0	10.8
2015	7	24	0	33	24	32		0	0	0	0	0	0	69.19	0	0	11
2015	7	24	0	43	24	32		0	0	0	0	0	0	69.15	0	0	10.8
2015	7	24	0	53	24	32		0	0	0	0	0	0	69.12	0	0	10.8
2015	7	24	1	3	24	32		0	0	0	0	0	0	69.1	0	0	10.8
2015	7	24	1	13	24	32		0	0	0	0	0	0	69.06	0	0	10.8
2015	7	24	1	23	24	32		0	0	0	0	0	0	69.03	0	0	10.8
2015	7	24	1	33	24	32		0	0	0	0	0	0	68.99	0	0	11.6
2015	7	24	1	43	24	32		0	0	0	0	0	0	68.95	0	0	11.4
2015	7	24	1	53	24	32		0	0	0	0	0	0	68.92	0	0	11
2015	7	24	2	3	24	32		0	0	0	0	0	0	68.88	0	0	11
2015	7	24	2	13	24	32		0	0	0	0	0	0	68.85	0	0	11
2015	7	24	2	23	24	32		0	0	0	0	0	0	68.81	0	0	11
2015	7	24	2	33	24	32		0	0	0	0	0	0	68.76	0	0	11.6
2015	7	24	2	43	24	32		0	0	0	0	0	0	68.72	0	0	11.6
2015	7	24	2	53	24	32		0	0	0	0	0	0	68.7	0	0	11.6
2015	7	24	3	3	24	32		0	0	0	0	0	0	68.67	0	0	11.6
2015	7	24	3	13	24	32		0	0	0	0	0	0	68.63	0	0	11.6
2015	7	24	3	23	24	32		0	0	0	0	0	0	68.58	0	0	11.6
2015	7	24	3	33	24	32		0	0	0	0	0	0	68.54	0	0	11.6
2015	7	24	3	43	24	32		0	0	0	0	0	0	68.5	0	0	11.6
2015	7	24	3	53	24	33		0	0	0	0	0	0	68.47	0	0	11.6
2015	7	24	4	3	24	31		0	0	0	0	0	0	68.41	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	24	4	13	24	32		0	0	0	0	0	0	68.38	0	0	11.6
2015	7	24	4	23	24	32		0	0	0	0	0	0	68.32	0	0	11.6
2015	7	24	4	33	24	32		0	0	0	0	0	0	68.27	0	0	11.6
2015	7	24	4	43	24	33		0	0	0	0	0	0	68.23	0	0	11.6
2015	7	24	4	53	24	32		0	0	0	0	0	0	68.18	0	0	11.6
2015	7	24	5	3	24	33		0	0	0	0	0	0	68.13	0	0	11.6
2015	7	24	5	13	24	32		0	0	0	0	0	0	68.09	0	0	11.6
2015	7	24	5	23	24	32		0	0	0	0	0	0	68.04	0	0	11.6
2015	7	24	5	33	24	32		0	0	0	0	0	0	68	0	0	11.6
2015	7	24	5	43	24	33		0	0	0	0	0	0	67.93	0	0	11.6
2015	7	24	5	53	24	33		0	0	0	0	0	0	67.87	0	0	11.6
2015	7	24	6	3	24	32		0	0	0	0	0	0	67.84	0	0	11.6
2015	7	24	6	13	24	32		0	0	0	0	0	0	67.78	0	0	11.6
2015	7	24	6	23	24	32		0	0	0	0	0	0	67.73	0	0	11.6
2015	7	24	6	33	24	32		0	0	0	0	0	0	67.69	0	0	11.6
2015	7	24	6	43	24	32		0	0	0	0	0	0	67.64	0	0	11.6
2015	7	24	6	53	24	34		0	0	0	0	0	0	67.59	0	0	11.6
2015	7	24	7	3	24	32		0	0	0	0	0	0	67.55	0	0	11.6
2015	7	24	7	13	24	33		0	0	0	0	0	0	67.51	0	0	11.8
2015	7	24	7	23	24	33		0	0	0	0	0	0	67.5	0	0	11.8
2015	7	24	7	33	24	32		0	0	0	0	0	0	67.5	0	0	11.8
2015	7	24	7	43	24	33		0	0	0	0	0	0	67.5	0	0	11.8
2015	7	24	7	53	24	32		0	0	0	0	0	0	67.48	0	0	11.8
2015	7	24	8	3	24	32		0	0	0	0	0	0	67.5	0	0	11.8
2015	7	24	8	13	24	32		0	0	0	0	0	0	67.5	0	0	12
2015	7	24	8	23	24	32		0	0	0	0	0	0	67.5	0	0	12
2015	7	24	8	33	24	33		0	0	0	0	0	0	67.51	0	0	12
2015	7	24	8	43	24	31		0	0	0	0	0	0	67.53	0	0	12
2015	7	24	8	53	24	32		0	0	0	0	0	0	67.55	0	0	12.2
2015	7	24	9	3	24	32		0	0	0	0	0	0	67.57	0	0	12.2
2015	7	24	9	13	24	32		0	0	0	0	0	0	67.59	0	0	12.2
2015	7	24	9	23	24	32		0	0	0	0	0	0	67.62	0	0	12.2
2015	7	24	9	33	24	32		0	0	0	0	0	0	67.66	0	0	12.2
2015	7	24	9	43	24	32		0	0	0	0	0	0	67.69	0	0	12.2
2015	7	24	9	53	24	33		0	0	0	0	0	0	67.75	0	0	12.2
2015	7	24	10	3	24	33		0	0	0	0	0	0	67.78	0	0	12.2
2015	7	24	10	13	24	32		0	0	0	0	0	0	67.82	0	0	12.6
2015	7	24	10	23	24	32		0	0	0	0	0	0	67.89	0	0	12.6
2015	7	24	10	33	24	32		0	0	0	0	0	0	67.93	0	0	12.6
2015	7	24	10	43	24	32		0	0	0	0	0	0	67.98	0	0	12.6
2015	7	24	10	53	24	32		0	0	0	0	0	0	68.04	0	0	12.4
2015	7	24	11	3	24	32		0	0	0	0	0	0	68.09	0	0	12.4
2015	7	24	11	13	24	32		0	0	0	0	0	0	68.14	0	0	12.4
2015	7	24	11	23	24	32		0	0	0	0	0	0	68.2	0	0	12.4
2015	7	24	11	33	24	32		0	0	0	0	0	0	68.25	0	0	12.2
2015	7	24	11	43	24	33		0	0	0	0	0	0	68.31	0	0	12.2
2015	7	24	11	53	24	33		0	0	0	0	0	0	68.36	0	0	12.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	24	12	3	24	32	0	0	0	0	0	0	0	68.41	0	0	12.6
2015	7	24	12	13	24	33	0	0	0	0	0	0	0	68.49	0	0	12.6
2015	7	24	12	23	24	32	0	0	0	0	0	0	0	68.54	0	0	12.6
2015	7	24	12	33	24	32	0	0	0	0	0	0	0	68.59	0	0	12.6
2015	7	24	12	43	24	31	0	0	0	0	0	0	0	68.67	0	0	13
2015	7	24	12	53	24	32	0	0	0	0	0	0	0	68.72	0	0	13
2015	7	24	13	3	24	32	0	0	0	0	0	0	0	68.77	0	0	12.6
2015	7	24	13	13	24	32	0	0	0	0	0	0	0	68.83	0	0	12.6
2015	7	24	13	23	24	32	0	0	0	0	0	0	0	68.88	0	0	12.6
2015	7	24	13	33	24	32	0	0	0	0	0	0	0	68.94	0	0	12.8
2015	7	24	13	43	24	32	0	0	0	0	0	0	0	69.01	0	0	12.8
2015	7	24	13	53	24	32	0	0	0	0	0	0	0	69.04	0	0	12.8
2015	7	24	14	3	24	32	0	0	0	0	0	0	0	69.1	0	0	12.6
2015	7	24	14	13	24	32	0	0	0	0	0	0	0	69.15	0	0	12.6
2015	7	24	14	23	24	33	0	0	0	0	0	0	0	69.19	0	0	12.6
2015	7	24	14	33	24	32	0	0	0	0	0	0	0	69.24	0	0	13
2015	7	24	14	43	24	32	0	0	0	0	0	0	0	69.28	0	0	13
2015	7	24	14	53	24	32	0	0	0	0	0	0	0	69.31	0	0	13
2015	7	24	15	3	24	32	0	0	0	0	0	0	0	69.35	0	0	13
2015	7	24	15	13	24	31	0	0	0	0	0	0	0	69.39	0	0	13
2015	7	24	15	23	24	33	0	0	0	0	0	0	0	69.4	0	0	13
2015	7	24	15	33	24	32	0	0	0	0	0	0	0	69.44	0	0	13
2015	7	24	15	43	24	32	0	0	0	0	0	0	0	69.48	0	0	12.8
2015	7	24	15	53	24	32	0	0	0	0	0	0	0	69.48	0	0	12.8
2015	7	24	16	3	24	32	0	0	0	0	0	0	0	69.49	0	0	12.6
2015	7	24	16	13	24	32	0	0	0	0	0	0	0	69.51	0	0	12.6
2015	7	24	16	23	24	32	0	0	0	0	0	0	0	69.53	0	0	12.6
2015	7	24	16	33	24	32	0	0	0	0	0	0	0	69.53	0	0	12.6
2015	7	24	16	43	24	32	0	0	0	0	0	0	0	69.53	0	0	12.6
2015	7	24	16	53	24	33	0	0	0	0	0	0	0	69.55	0	0	12.4
2015	7	24	17	3	24	33	0	0	0	0	0	0	0	69.55	0	0	12.4
2015	7	24	17	13	24	32	0	0	0	0	0	0	0	69.57	0	0	12.4
2015	7	24	17	23	24	32	0	0	0	0	0	0	0	69.55	0	0	12.4
2015	7	24	17	33	24	32	0	0	0	0	0	0	0	69.55	0	0	12
2015	7	24	17	43	24	32	0	0	0	0	0	0	0	69.55	0	0	12
2015	7	24	17	53	24	33	0	0	0	0	0	0	0	69.51	0	0	11.8
2015	7	24	18	3	24	32	0	0	0	0	0	0	0	69.51	0	0	11.6
2015	7	24	18	13	24	33	0	0	0	0	0	0	0	69.49	0	0	11.4
2015	7	24	18	23	24	32	0	0	0	0	0	0	0	69.49	0	0	11.4
2015	7	24	18	33	24	32	0	0	0	0	0	0	0	69.49	0	0	11.2
2015	7	24	18	43	24	33	0	0	0	0	0	0	0	69.49	0	0	11.2
2015	7	24	18	53	24	32	0	0	0	0	0	0	0	69.49	0	0	11.2
2015	7	24	19	3	24	32	0	0	0	0	0	0	0	69.49	0	0	11.2
2015	7	24	19	13	24	32	0	0	0	0	0	0	0	69.48	0	0	11.2
2015	7	24	19	23	24	32	0	0	0	0	0	0	0	69.48	0	0	11
2015	7	24	19	33	24	32	0	0	0	0	0	0	0	69.48	0	0	11.2
2015	7	24	19	43	24	33	0	0	0	0	0	0	0	69.48	0	0	11

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	24	19	53	24	33	0	0	0	0	0	0	0	69.46	0	0	11
2015	7	24	20	3	24	32	0	0	0	0	0	0	0	69.44	0	0	11
2015	7	24	20	13	24	32	0	0	0	0	0	0	0	69.44	0	0	11
2015	7	24	20	23	24	32	0	0	0	0	0	0	0	69.4	0	0	10.8
2015	7	24	20	33	24	32	0	0	0	0	0	0	0	69.39	0	0	11
2015	7	24	20	43	24	32	0	0	0	0	0	0	0	69.37	0	0	10.8
2015	7	24	20	53	24	32	0	0	0	0	0	0	0	69.35	0	0	10.8
2015	7	24	21	3	24	32	0	0	0	0	0	0	0	69.33	0	0	10.8
2015	7	24	21	13	24	33	0	0	0	0	0	0	0	69.31	0	0	10.8
2015	7	24	21	23	24	32	0	0	0	0	0	0	0	69.3	0	0	10.8
2015	7	24	21	33	24	32	0	0	0	0	0	0	0	69.26	0	0	11
2015	7	24	21	43	24	32	0	0	0	0	0	0	0	69.24	0	0	11
2015	7	24	21	53	24	32	0	0	0	0	0	0	0	69.21	0	0	11
2015	7	24	22	3	24	33	0	0	0	0	0	0	0	69.17	0	0	10.8
2015	7	24	22	13	24	32	0	0	0	0	0	0	0	69.13	0	0	10.8
2015	7	24	22	23	24	33	0	0	0	0	0	0	0	69.1	0	0	10.8
2015	7	24	22	33	24	32	0	0	0	0	0	0	0	69.06	0	0	11
2015	7	24	22	43	24	33	0	0	0	0	0	0	0	69.03	0	0	10.8
2015	7	24	22	53	24	33	0	0	0	0	0	0	0	68.99	0	0	10.8
2015	7	24	23	3	24	32	0	0	0	0	0	0	0	68.95	0	0	10.8
2015	7	24	23	13	24	32	0	0	0	0	0	0	0	68.94	0	0	10.8
2015	7	24	23	23	24	32	0	0	0	0	0	0	0	68.9	0	0	10.8
2015	7	24	23	33	24	32	0	0	0	0	0	0	0	68.86	0	0	10.8
2015	7	24	23	43	24	33	0	0	0	0	0	0	0	68.85	0	0	10.8
2015	7	24	23	53	24	32	0	0	0	0	0	0	0	68.81	0	0	10.8
2015	7	25	0	3	24	32	0	0	0	0	0	0	0	68.79	0	0	10.8
2015	7	25	0	13	24	32	0	0	0	0	0	0	0	68.76	0	0	10.8
2015	7	25	0	23	24	32	0	0	0	0	0	0	0	68.74	0	0	10.8
2015	7	25	0	33	24	32	0	0	0	0	0	0	0	68.72	0	0	10.8
2015	7	25	0	43	24	31	0	0	0	0	0	0	0	68.68	0	0	10.8
2015	7	25	0	53	24	32	0	0	0	0	0	0	0	68.67	0	0	10.8
2015	7	25	1	3	24	32	0	0	0	0	0	0	0	68.63	0	0	10.8
2015	7	25	1	13	24	32	0	0	0	0	0	0	0	68.59	0	0	10.8
2015	7	25	1	23	24	32	0	0	0	0	0	0	0	68.58	0	0	10.8
2015	7	25	1	33	24	33	0	0	0	0	0	0	0	68.54	0	0	11.6
2015	7	25	1	43	24	32	0	0	0	0	0	0	0	68.5	0	0	11.6
2015	7	25	1	53	24	32	0	0	0	0	0	0	0	68.49	0	0	11.6
2015	7	25	2	3	24	32	0	0	0	0	0	0	0	68.45	0	0	11.6
2015	7	25	2	13	24	32	0	0	0	0	0	0	0	68.41	0	0	11.6
2015	7	25	2	23	24	33	0	0	0	0	0	0	0	68.4	0	0	11.6
2015	7	25	2	33	24	32	0	0	0	0	0	0	0	68.34	0	0	11.6
2015	7	25	2	43	24	32	0	0	0	0	0	0	0	68.31	0	0	11.6
2015	7	25	2	53	24	32	0	0	0	0	0	0	0	68.29	0	0	11.6
2015	7	25	3	3	24	32	0	0	0	0	0	0	0	68.25	0	0	11.6
2015	7	25	3	13	24	32	0	0	0	0	0	0	0	68.22	0	0	11.6
2015	7	25	3	23	24	33	0	0	0	0	0	0	0	68.16	0	0	11.6
2015	7	25	3	33	24	33	0	0	0	0	0	0	0	68.13	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	25	3	43	24	33		0	0	0	0	0	0	68.09	0	0	11.6
2015	7	25	3	53	24	32		0	0	0	0	0	0	68.04	0	0	11.6
2015	7	25	4	3	24	32		0	0	0	0	0	0	68	0	0	11.6
2015	7	25	4	13	24	32		0	0	0	0	0	0	67.96	0	0	11.6
2015	7	25	4	23	24	32		0	0	0	0	0	0	67.93	0	0	11.6
2015	7	25	4	33	24	32		0	0	0	0	0	0	67.87	0	0	11.6
2015	7	25	4	43	24	32		0	0	0	0	0	0	67.84	0	0	11.6
2015	7	25	4	53	24	32		0	0	0	0	0	0	67.78	0	0	11.6
2015	7	25	5	3	24	33		0	0	0	0	0	0	67.73	0	0	11.6
2015	7	25	5	13	24	32		0	0	0	0	0	0	67.68	0	0	11.6
2015	7	25	5	23	24	32		0	0	0	0	0	0	67.64	0	0	11.6
2015	7	25	5	33	24	33		0	0	0	0	0	0	67.59	0	0	11.6
2015	7	25	5	43	24	32		0	0	0	0	0	0	67.55	0	0	11.6
2015	7	25	5	53	24	32		0	0	0	0	0	0	67.5	0	0	11.6
2015	7	25	6	3	24	32		0	0	0	0	0	0	67.44	0	0	11.6
2015	7	25	6	13	24	32		0	0	0	0	0	0	67.41	0	0	11.6
2015	7	25	6	23	24	32		0	0	0	0	0	0	67.35	0	0	11.6
2015	7	25	6	33	24	32		0	0	0	0	0	0	67.32	0	0	11.6
2015	7	25	6	43	24	31		0	0	0	0	0	0	67.28	0	0	11.6
2015	7	25	6	53	24	33		0	0	0	0	0	0	67.24	0	0	11.6
2015	7	25	7	3	24	33		0	0	0	0	0	0	67.21	0	0	11.6
2015	7	25	7	13	24	32		0	0	0	0	0	0	67.15	0	0	11.8
2015	7	25	7	23	24	33		0	0	0	0	0	0	67.15	0	0	11.8
2015	7	25	7	33	24	32		0	0	0	0	0	0	67.15	0	0	11.8
2015	7	25	7	43	24	33		0	0	0	0	0	0	67.14	0	0	11.8
2015	7	25	7	53	24	32		0	0	0	0	0	0	67.14	0	0	12.8
2015	7	25	8	3	24	32		0	0	0	0	0	0	67.14	0	0	13
2015	7	25	8	13	24	33		0	0	0	0	0	0	67.14	0	0	12.6
2015	7	25	8	23	24	33		0	0	0	0	0	0	67.14	0	0	12.8
2015	7	25	8	33	24	33		0	0	0	0	0	0	67.15	0	0	12.6
2015	7	25	8	43	24	33		0	0	0	0	0	0	67.15	0	0	12.6
2015	7	25	8	53	24	32		0	0	0	0	0	0	67.17	0	0	12.6
2015	7	25	9	3	24	32		0	0	0	0	0	0	67.19	0	0	12.6
2015	7	25	9	13	24	33		0	0	0	0	0	0	67.23	0	0	12.6
2015	7	25	9	23	24	32		0	0	0	0	0	0	67.26	0	0	12.8
2015	7	25	9	33	24	32		0	0	0	0	0	0	67.32	0	0	12.8
2015	7	25	9	43	24	33		0	0	0	0	0	0	67.33	0	0	12.6
2015	7	25	9	53	24	32		0	0	0	0	0	0	67.41	0	0	12.6
2015	7	25	10	3	24	32		0	0	0	0	0	0	67.44	0	0	12.4
2015	7	25	10	13	24	32		0	0	0	0	0	0	67.51	0	0	12.2
2015	7	25	10	23	24	33		0	0	0	0	0	0	67.55	0	0	12.6
2015	7	25	10	33	24	32		0	0	0	0	0	0	67.6	0	0	13.4
2015	7	25	10	43	24	32		0	0	0	0	0	0	67.68	0	0	13.2
2015	7	25	10	53	24	33		0	0	0	0	0	0	67.71	0	0	13
2015	7	25	11	3	24	32		0	0	0	0	0	0	67.78	0	0	12.8
2015	7	25	11	13	24	32		0	0	0	0	0	0	67.86	0	0	12.6
2015	7	25	11	23	24	32		0	0	0	0	0	0	67.93	0	0	12.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	25	11	33	24	32		0	0	0	0	0	0	67.98	0	0	13.4
2015	7	25	11	43	24	33		0	0	0	0	0	0	68.05	0	0	13.2
2015	7	25	11	53	24	33		0	0	0	0	0	0	68.11	0	0	13
2015	7	25	12	3	24	32		0	0	0	0	0	0	68.16	0	0	13.2
2015	7	25	12	13	24	32		0	0	0	0	0	0	68.23	0	0	13
2015	7	25	12	23	24	32		0	0	0	0	0	0	68.29	0	0	12.6
2015	7	25	12	33	24	33		0	0	0	0	0	0	68.34	0	0	13
2015	7	25	12	43	24	32		0	0	0	0	0	0	68.43	0	0	12.8
2015	7	25	12	53	24	33		0	0	0	0	0	0	68.47	0	0	12.6
2015	7	25	13	3	24	32		0	0	0	0	0	0	68.52	0	0	12.6
2015	7	25	13	13	24	32		0	0	0	0	0	0	68.59	0	0	12.6
2015	7	25	13	23	24	32		0	0	0	0	0	0	68.65	0	0	12.6
2015	7	25	13	33	24	33		0	0	0	0	0	0	68.72	0	0	13.4
2015	7	25	13	43	24	32		0	0	0	0	0	0	68.76	0	0	13
2015	7	25	13	53	24	32		0	0	0	0	0	0	68.79	0	0	12.8
2015	7	25	14	3	24	32		0	0	0	0	0	0	68.85	0	0	12.8
2015	7	25	14	13	24	32		0	0	0	0	0	0	68.92	0	0	12.6
2015	7	25	14	23	24	33		0	0	0	0	0	0	68.97	0	0	12.6
2015	7	25	14	33	24	33		0	0	0	0	0	0	69.03	0	0	12.8
2015	7	25	14	43	24	33		0	0	0	0	0	0	69.06	0	0	13
2015	7	25	14	53	24	33		0	0	0	0	0	0	69.1	0	0	12.8
2015	7	25	15	3	24	32		0	0	0	0	0	0	69.13	0	0	12.8
2015	7	25	15	13	24	33		0	0	0	0	0	0	69.17	0	0	12.8
2015	7	25	15	23	24	32		0	0	0	0	0	0	69.22	0	0	12.8
2015	7	25	15	33	24	33		0	0	0	0	0	0	69.22	0	0	13
2015	7	25	15	43	24	32		0	0	0	0	0	0	69.26	0	0	13
2015	7	25	15	53	24	32		0	0	0	0	0	0	69.28	0	0	12.8
2015	7	25	16	3	24	32		0	0	0	0	0	0	69.28	0	0	12.8
2015	7	25	16	13	24	32		0	0	0	0	0	0	69.31	0	0	12.6
2015	7	25	16	23	24	32		0	0	0	0	0	0	69.33	0	0	12.6
2015	7	25	16	33	24	32		0	0	0	0	0	0	69.33	0	0	12.8
2015	7	25	16	43	24	32		0	0	0	0	0	0	69.33	0	0	12.6
2015	7	25	16	53	24	33		0	0	0	0	0	0	69.35	0	0	12.6
2015	7	25	17	3	24	32		0	0	0	0	0	0	69.35	0	0	12.4
2015	7	25	17	13	24	32		0	0	0	0	0	0	69.35	0	0	12.2
2015	7	25	17	23	24	31		0	0	0	0	0	0	69.35	0	0	12.2
2015	7	25	17	33	24	32		0	0	0	0	0	0	69.35	0	0	12
2015	7	25	17	43	24	33		0	0	0	0	0	0	69.35	0	0	11.8
2015	7	25	17	53	24	32		0	0	0	0	0	0	69.33	0	0	11.8
2015	7	25	18	3	24	33		0	0	0	0	0	0	69.31	0	0	11.6
2015	7	25	18	13	24	32		0	0	0	0	0	0	69.31	0	0	11.4
2015	7	25	18	23	24	32		0	0	0	0	0	0	69.31	0	0	11.4
2015	7	25	18	33	24	32		0	0	0	0	0	0	69.31	0	0	11.4
2015	7	25	18	43	24	33		0	0	0	0	0	0	69.31	0	0	11.2
2015	7	25	18	53	24	32		0	0	0	0	0	0	69.31	0	0	11.2
2015	7	25	19	3	24	32		0	0	0	0	0	0	69.31	0	0	11.2
2015	7	25	19	13	24	32		0	0	0	0	0	0	69.31	0	0	11.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	25	19	23	24	32		0	0	0	0	0	0	69.31	0	0	11.2
2015	7	25	19	33	24	33		0	0	0	0	0	0	69.3	0	0	11
2015	7	25	19	43	24	32		0	0	0	0	0	0	69.3	0	0	11
2015	7	25	19	53	24	33		0	0	0	0	0	0	69.28	0	0	10.8
2015	7	25	20	3	24	32		0	0	0	0	0	0	69.26	0	0	10.8
2015	7	25	20	13	24	32		0	0	0	0	0	0	69.26	0	0	10.8
2015	7	25	20	23	24	32		0	0	0	0	0	0	69.26	0	0	10.6
2015	7	25	20	33	24	32		0	0	0	0	0	0	69.24	0	0	10.8
2015	7	25	20	43	24	32		0	0	0	0	0	0	69.22	0	0	10.6
2015	7	25	20	53	24	33		0	0	0	0	0	0	69.21	0	0	10.6
2015	7	25	21	3	24	31		0	0	0	0	0	0	69.19	0	0	10.6
2015	7	25	21	13	24	32		0	0	0	0	0	0	69.17	0	0	10.6
2015	7	25	21	23	24	32		0	0	0	0	0	0	69.15	0	0	10.6
2015	7	25	21	33	24	32		0	0	0	0	0	0	69.12	0	0	11.8
2015	7	25	21	43	24	32		0	0	0	0	0	0	69.1	0	0	11.8
2015	7	25	21	53	24	32		0	0	0	0	0	0	69.06	0	0	11.8
2015	7	25	22	3	24	32		0	0	0	0	0	0	69.03	0	0	11.8
2015	7	25	22	13	24	32		0	0	0	0	0	0	68.99	0	0	11.8
2015	7	25	22	23	24	32		0	0	0	0	0	0	68.97	0	0	11.8
2015	7	25	22	33	24	32		0	0	0	0	0	0	68.94	0	0	11.8
2015	7	25	22	43	24	33		0	0	0	0	0	0	68.92	0	0	11.8
2015	7	25	22	53	24	32		0	0	0	0	0	0	68.86	0	0	11.8
2015	7	25	23	3	24	32		0	0	0	0	0	0	68.85	0	0	11.8
2015	7	25	23	13	24	32		0	0	0	0	0	0	68.81	0	0	11.8
2015	7	25	23	23	24	32		0	0	0	0	0	0	68.77	0	0	10.8
2015	7	25	23	33	24	32		0	0	0	0	0	0	68.74	0	0	11.4
2015	7	25	23	43	24	33		0	0	0	0	0	0	68.72	0	0	11.4
2015	7	25	23	53	24	32		0	0	0	0	0	0	68.68	0	0	11.4
2015	7	26	0	3	24	32		0	0	0	0	0	0	68.65	0	0	11.4
2015	7	26	0	13	24	32		0	0	0	0	0	0	68.61	0	0	11.4
2015	7	26	0	23	24	32		0	0	0	0	0	0	68.58	0	0	11.6
2015	7	26	0	33	24	33		0	0	0	0	0	0	68.52	0	0	11.4
2015	7	26	0	43	24	32		0	0	0	0	0	0	68.49	0	0	11.4
2015	7	26	0	53	24	32		0	0	0	0	0	0	68.45	0	0	11.4
2015	7	26	1	3	24	32		0	0	0	0	0	0	68.41	0	0	11.4
2015	7	26	1	13	24	32		0	0	0	0	0	0	68.38	0	0	11.4
2015	7	26	1	23	24	33		0	0	0	0	0	0	68.34	0	0	11.4
2015	7	26	1	33	24	32		0	0	0	0	0	0	68.31	0	0	11.4
2015	7	26	1	43	24	33		0	0	0	0	0	0	68.27	0	0	11.4
2015	7	26	1	53	24	33		0	0	0	0	0	0	68.22	0	0	11.4
2015	7	26	2	3	24	32		0	0	0	0	0	0	68.18	0	0	11.4
2015	7	26	2	13	24	32		0	0	0	0	0	0	68.14	0	0	11.4
2015	7	26	2	23	24	32		0	0	0	0	0	0	68.11	0	0	11.4
2015	7	26	2	33	24	33		0	0	0	0	0	0	68.07	0	0	11.4
2015	7	26	2	43	24	32		0	0	0	0	0	0	68.04	0	0	11.4
2015	7	26	2	53	24	32		0	0	0	0	0	0	68	0	0	11.4
2015	7	26	3	3	24	32		0	0	0	0	0	0	67.95	0	0	11.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	26	3	13	24	32		0	0	0	0	0	0	67.91	0	0	11.4
2015	7	26	3	23	24	33		0	0	0	0	0	0	67.87	0	0	11.4
2015	7	26	3	33	24	33		0	0	0	0	0	0	67.84	0	0	11.4
2015	7	26	3	43	24	32		0	0	0	0	0	0	67.78	0	0	11.4
2015	7	26	3	53	24	32		0	0	0	0	0	0	67.73	0	0	11.4
2015	7	26	4	3	24	32		0	0	0	0	0	0	67.68	0	0	11.4
2015	7	26	4	13	24	33		0	0	0	0	0	0	67.64	0	0	11.4
2015	7	26	4	23	24	33		0	0	0	0	0	0	67.57	0	0	11.4
2015	7	26	4	33	24	33		0	0	0	0	0	0	67.51	0	0	11.4
2015	7	26	4	43	24	33		0	0	0	0	0	0	67.48	0	0	11.4
2015	7	26	4	53	24	32		0	0	0	0	0	0	67.42	0	0	11.4
2015	7	26	5	3	24	33		0	0	0	0	0	0	67.37	0	0	11.4
2015	7	26	5	13	24	32		0	0	0	0	0	0	67.33	0	0	11.4
2015	7	26	5	23	24	32		0	0	0	0	0	0	67.28	0	0	11.4
2015	7	26	5	33	24	32		0	0	0	0	0	0	67.23	0	0	11.4
2015	7	26	5	43	24	33		0	0	0	0	0	0	67.15	0	0	11.4
2015	7	26	5	53	24	33		0	0	0	0	0	0	67.08	0	0	11.4
2015	7	26	6	3	24	33		0	0	0	0	0	0	67.03	0	0	11.4
2015	7	26	6	13	24	32		0	0	0	0	0	0	66.97	0	0	11.4
2015	7	26	6	23	24	32		0	0	0	0	0	0	66.9	0	0	11.4
2015	7	26	6	33	24	31		0	0	0	0	0	0	66.87	0	0	11.4
2015	7	26	6	43	24	32		0	0	0	0	0	0	66.83	0	0	11.4
2015	7	26	6	53	24	32		0	0	0	0	0	0	66.76	0	0	11.4
2015	7	26	7	3	24	33		0	0	0	0	0	0	66.72	0	0	11.4
2015	7	26	7	13	24	33		0	0	0	0	0	0	66.67	0	0	11.4
2015	7	26	7	23	24	33		0	0	0	0	0	0	66.65	0	0	11.6
2015	7	26	7	33	24	33		0	0	0	0	0	0	66.63	0	0	11.6
2015	7	26	7	43	24	32		0	0	0	0	0	0	66.61	0	0	11.6
2015	7	26	7	53	24	33		0	0	0	0	0	0	66.6	0	0	11.6
2015	7	26	8	3	24	33		0	0	0	0	0	0	66.6	0	0	11.8
2015	7	26	8	13	24	33		0	0	0	0	0	0	66.6	0	0	11.8
2015	7	26	8	23	24	32		0	0	0	0	0	0	66.6	0	0	11.8
2015	7	26	8	33	24	32		0	0	0	0	0	0	66.61	0	0	12
2015	7	26	8	43	24	32		0	0	0	0	0	0	66.61	0	0	12
2015	7	26	8	53	24	32		0	0	0	0	0	0	66.63	0	0	12
2015	7	26	9	3	24	33		0	0	0	0	0	0	66.65	0	0	12
2015	7	26	9	13	24	32		0	0	0	0	0	0	66.67	0	0	12
2015	7	26	9	23	24	34		0	0	0	0	0	0	66.7	0	0	12.4
2015	7	26	9	33	24	33		0	0	0	0	0	0	66.74	0	0	13.2
2015	7	26	9	43	24	32		0	0	0	0	0	0	66.78	0	0	13
2015	7	26	9	53	24	33		0	0	0	0	0	0	66.83	0	0	12.8
2015	7	26	10	3	24	32		0	0	0	0	0	0	66.87	0	0	13
2015	7	26	10	13	24	32		0	0	0	0	0	0	66.9	0	0	12.6
2015	7	26	10	23	24	32		0	0	0	0	0	0	66.97	0	0	12.6
2015	7	26	10	33	24	33		0	0	0	0	0	0	67.03	0	0	13
2015	7	26	10	43	24	32		0	0	0	0	0	0	67.06	0	0	12.6
2015	7	26	10	53	24	32		0	0	0	0	0	0	67.14	0	0	12.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	26	11	3	24	32	0	0	0	0	0	0	0	67.21	0	0	12.4
2015	7	26	11	13	24	32	0	0	0	0	0	0	0	67.26	0	0	12.4
2015	7	26	11	23	24	33	0	0	0	0	0	0	0	67.3	0	0	12.4
2015	7	26	11	33	24	32	0	0	0	0	0	0	0	67.37	0	0	12.8
2015	7	26	11	43	24	32	0	0	0	0	0	0	0	67.42	0	0	12.8
2015	7	26	11	53	24	32	0	0	0	0	0	0	0	67.5	0	0	12.8
2015	7	26	12	3	24	32	0	0	0	0	0	0	0	67.55	0	0	12.8
2015	7	26	12	13	24	32	0	0	0	0	0	0	0	67.62	0	0	12.8
2015	7	26	12	23	24	32	0	0	0	0	0	0	0	67.69	0	0	12.8
2015	7	26	12	33	24	32	0	0	0	0	0	0	0	67.77	0	0	13.2
2015	7	26	12	43	24	33	0	0	0	0	0	0	0	67.84	0	0	13
2015	7	26	12	53	24	32	0	0	0	0	0	0	0	67.89	0	0	13
2015	7	26	13	3	24	32	0	0	0	0	0	0	0	67.95	0	0	13
2015	7	26	13	13	24	32	0	0	0	0	0	0	0	68.02	0	0	13
2015	7	26	13	23	24	32	0	0	0	0	0	0	0	68.09	0	0	13
2015	7	26	13	33	24	33	0	0	0	0	0	0	0	68.13	0	0	13
2015	7	26	13	43	24	32	0	0	0	0	0	0	0	68.2	0	0	13.2
2015	7	26	13	53	24	32	0	0	0	0	0	0	0	68.25	0	0	13
2015	7	26	14	3	24	32	0	0	0	0	0	0	0	68.31	0	0	12.8
2015	7	26	14	13	24	32	0	0	0	0	0	0	0	68.36	0	0	12.8
2015	7	26	14	23	24	32	0	0	0	0	0	0	0	68.41	0	0	12.8
2015	7	26	14	33	24	32	0	0	0	0	0	0	0	68.45	0	0	13
2015	7	26	14	43	24	32	0	0	0	0	0	0	0	68.49	0	0	13
2015	7	26	14	53	24	32	0	0	0	0	0	0	0	68.49	0	0	13
2015	7	26	15	3	24	32	0	0	0	0	0	0	0	68.58	0	0	12.8
2015	7	26	15	13	24	32	0	0	0	0	0	0	0	68.58	0	0	12.8
2015	7	26	15	23	24	32	0	0	0	0	0	0	0	68.63	0	0	12.8
2015	7	26	15	33	24	32	0	0	0	0	0	0	0	68.68	0	0	12.8
2015	7	26	15	43	24	32	0	0	0	0	0	0	0	68.72	0	0	12.8
2015	7	26	15	53	24	32	0	0	0	0	0	0	0	68.74	0	0	12.8
2015	7	26	16	3	24	33	0	0	0	0	0	0	0	68.76	0	0	12.8
2015	7	26	16	13	24	33	0	0	0	0	0	0	0	68.79	0	0	12.6
2015	7	26	16	23	24	32	0	0	0	0	0	0	0	68.79	0	0	12.6
2015	7	26	16	33	24	32	0	0	0	0	0	0	0	68.83	0	0	12.4
2015	7	26	16	43	24	33	0	0	0	0	0	0	0	68.83	0	0	12.4
2015	7	26	16	53	24	33	0	0	0	0	0	0	0	68.83	0	0	12.4
2015	7	26	17	3	24	32	0	0	0	0	0	0	0	68.83	0	0	12.4
2015	7	26	17	13	24	32	0	0	0	0	0	0	0	68.85	0	0	12.2
2015	7	26	17	23	24	32	0	0	0	0	0	0	0	68.83	0	0	12.2
2015	7	26	17	33	24	32	0	0	0	0	0	0	0	68.83	0	0	12
2015	7	26	17	43	24	32	0	0	0	0	0	0	0	68.83	0	0	12
2015	7	26	17	53	24	33	0	0	0	0	0	0	0	68.79	0	0	12
2015	7	26	18	3	24	32	0	0	0	0	0	0	0	68.79	0	0	11.8
2015	7	26	18	13	24	31	0	0	0	0	0	0	0	68.79	0	0	11.8
2015	7	26	18	23	24	32	0	0	0	0	0	0	0	68.81	0	0	11.8
2015	7	26	18	33	24	32	0	0	0	0	0	0	0	68.79	0	0	11.8
2015	7	26	18	43	24	32	0	0	0	0	0	0	0	68.79	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	26	18	53	24	32		0	0	0	0	0	0	68.79	0	0	11.8
2015	7	26	19	3	24	32		0	0	0	0	0	0	68.79	0	0	11.8
2015	7	26	19	13	24	32		0	0	0	0	0	0	68.79	0	0	11
2015	7	26	19	23	24	32		0	0	0	0	0	0	68.79	0	0	10.8
2015	7	26	19	33	24	33		0	0	0	0	0	0	68.79	0	0	11
2015	7	26	19	43	24	32		0	0	0	0	0	0	68.79	0	0	11
2015	7	26	19	53	24	32		0	0	0	0	0	0	68.79	0	0	11
2015	7	26	20	3	24	32		0	0	0	0	0	0	68.77	0	0	11
2015	7	26	20	13	24	32		0	0	0	0	0	0	68.77	0	0	10.8
2015	7	26	20	23	24	32		0	0	0	0	0	0	68.76	0	0	10.8
2015	7	26	20	33	24	32		0	0	0	0	0	0	68.74	0	0	11.6
2015	7	26	20	43	24	32		0	0	0	0	0	0	68.72	0	0	11.6
2015	7	26	20	53	24	33		0	0	0	0	0	0	68.7	0	0	11.6
2015	7	26	21	3	24	32		0	0	0	0	0	0	68.68	0	0	11.6
2015	7	26	21	13	24	32		0	0	0	0	0	0	68.67	0	0	11.6
2015	7	26	21	23	24	32		0	0	0	0	0	0	68.63	0	0	11.6
2015	7	26	21	33	24	32		0	0	0	0	0	0	68.61	0	0	11.8
2015	7	26	21	43	24	32		0	0	0	0	0	0	68.58	0	0	11.8
2015	7	26	21	53	24	32		0	0	0	0	0	0	68.56	0	0	11.8
2015	7	26	22	3	24	32		0	0	0	0	0	0	68.52	0	0	11.8
2015	7	26	22	13	24	31		0	0	0	0	0	0	68.5	0	0	11.8
2015	7	26	22	23	24	32		0	0	0	0	0	0	68.47	0	0	11.8
2015	7	26	22	33	24	32		0	0	0	0	0	0	68.43	0	0	11.8
2015	7	26	22	43	24	32		0	0	0	0	0	0	68.41	0	0	11.8
2015	7	26	22	53	24	33		0	0	0	0	0	0	68.38	0	0	11.8
2015	7	26	23	3	24	32		0	0	0	0	0	0	68.34	0	0	11.8
2015	7	26	23	13	24	32		0	0	0	0	0	0	68.32	0	0	11.8
2015	7	26	23	23	24	32		0	0	0	0	0	0	68.29	0	0	11.6
2015	7	26	23	33	24	33		0	0	0	0	0	0	68.27	0	0	11.6
2015	7	26	23	43	24	32		0	0	0	0	0	0	68.23	0	0	11.6
2015	7	26	23	53	24	32		0	0	0	0	0	0	68.2	0	0	11.6
2015	7	27	0	3	24	32		0	0	0	0	0	0	68.16	0	0	11.6
2015	7	27	0	13	24	32		0	0	0	0	0	0	68.13	0	0	11.6
2015	7	27	0	23	24	32		0	0	0	0	0	0	68.11	0	0	11.6
2015	7	27	0	33	24	33		0	0	0	0	0	0	68.05	0	0	11.6
2015	7	27	0	43	24	33		0	0	0	0	0	0	68.02	0	0	11.6
2015	7	27	0	53	24	32		0	0	0	0	0	0	67.98	0	0	11.6
2015	7	27	1	3	24	33		0	0	0	0	0	0	67.95	0	0	11.6
2015	7	27	1	13	24	32		0	0	0	0	0	0	67.91	0	0	11.6
2015	7	27	1	23	24	32		0	0	0	0	0	0	67.86	0	0	11.6
2015	7	27	1	33	24	32		0	0	0	0	0	0	67.82	0	0	11.6
2015	7	27	1	43	24	32		0	0	0	0	0	0	67.77	0	0	11.6
2015	7	27	1	53	24	33		0	0	0	0	0	0	67.71	0	0	11.6
2015	7	27	2	3	24	33		0	0	0	0	0	0	67.66	0	0	11.6
2015	7	27	2	13	24	32		0	0	0	0	0	0	67.6	0	0	11.6
2015	7	27	2	23	24	32		0	0	0	0	0	0	67.57	0	0	11.6
2015	7	27	2	33	24	32		0	0	0	0	0	0	67.51	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	27	2	43	24	33		0	0	0	0	0	0	67.48	0	0	11.6
2015	7	27	2	53	24	33		0	0	0	0	0	0	67.42	0	0	11.6
2015	7	27	3	3	24	32		0	0	0	0	0	0	67.37	0	0	11.6
2015	7	27	3	13	24	33		0	0	0	0	0	0	67.32	0	0	11.6
2015	7	27	3	23	24	32		0	0	0	0	0	0	67.26	0	0	11.6
2015	7	27	3	33	24	32		0	0	0	0	0	0	67.21	0	0	11.6
2015	7	27	3	43	24	32		0	0	0	0	0	0	67.15	0	0	11.6
2015	7	27	3	53	24	33		0	0	0	0	0	0	67.1	0	0	11.6
2015	7	27	4	3	24	33		0	0	0	0	0	0	67.05	0	0	11.6
2015	7	27	4	13	24	33		0	0	0	0	0	0	66.99	0	0	11.6
2015	7	27	4	23	24	33		0	0	0	0	0	0	66.96	0	0	11.6
2015	7	27	4	33	24	32		0	0	0	0	0	0	66.92	0	0	11.6
2015	7	27	4	43	24	32		0	0	0	0	0	0	66.88	0	0	11.6
2015	7	27	4	53	24	32		0	0	0	0	0	0	66.85	0	0	11.6
2015	7	27	5	3	24	33		0	0	0	0	0	0	66.81	0	0	11.6
2015	7	27	5	13	24	33		0	0	0	0	0	0	66.78	0	0	11.6
2015	7	27	5	23	24	32		0	0	0	0	0	0	66.74	0	0	11.6
2015	7	27	5	33	24	32		0	0	0	0	0	0	66.7	0	0	11.6
2015	7	27	5	43	24	32		0	0	0	0	0	0	66.67	0	0	11.6
2015	7	27	5	53	24	33		0	0	0	0	0	0	66.61	0	0	11.6
2015	7	27	6	3	24	32		0	0	0	0	0	0	66.6	0	0	11.6
2015	7	27	6	13	24	32		0	0	0	0	0	0	66.54	0	0	11.6
2015	7	27	6	23	24	33		0	0	0	0	0	0	66.51	0	0	11.6
2015	7	27	6	33	24	32		0	0	0	0	0	0	66.47	0	0	11.6
2015	7	27	6	43	24	33		0	0	0	0	0	0	66.42	0	0	11.6
2015	7	27	6	53	24	33		0	0	0	0	0	0	66.38	0	0	11.6
2015	7	27	7	3	24	33		0	0	0	0	0	0	66.34	0	0	11.8
2015	7	27	7	13	24	32		0	0	0	0	0	0	66.31	0	0	11.8
2015	7	27	7	23	24	33		0	0	0	0	0	0	66.29	0	0	11.8
2015	7	27	7	33	24	32		0	0	0	0	0	0	66.27	0	0	11.8
2015	7	27	7	43	24	33		0	0	0	0	0	0	66.27	0	0	11.8
2015	7	27	7	53	24	32		0	0	0	0	0	0	66.27	0	0	12
2015	7	27	8	3	24	32		0	0	0	0	0	0	66.27	0	0	12
2015	7	27	8	13	24	33		0	0	0	0	0	0	66.25	0	0	12
2015	7	27	8	23	24	32		0	0	0	0	0	0	66.24	0	0	12
2015	7	27	8	33	24	32		0	0	0	0	0	0	66.24	0	0	12.2
2015	7	27	8	43	24	33		0	0	0	0	0	0	66.22	0	0	12.2
2015	7	27	8	53	24	32		0	0	0	0	0	0	66.22	0	0	12.2
2015	7	27	9	3	24	33		0	0	0	0	0	0	66.24	0	0	12.2
2015	7	27	9	13	24	33		0	0	0	0	0	0	66.27	0	0	12.4
2015	7	27	9	23	24	33		0	0	0	0	0	0	66.29	0	0	12.4
2015	7	27	9	33	24	33		0	0	0	0	0	0	66.31	0	0	12.4
2015	7	27	9	43	24	33		0	0	0	0	0	0	66.34	0	0	12.4
2015	7	27	9	53	24	33		0	0	0	0	0	0	66.38	0	0	12.8
2015	7	27	10	3	24	32		0	0	0	0	0	0	66.42	0	0	12.8
2015	7	27	10	13	24	32		0	0	0	0	0	0	66.45	0	0	12.8
2015	7	27	10	23	24	33		0	0	0	0	0	0	66.49	0	0	12.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	27	10	33	24	32		0	0	0	0	0	0	66.54	0	0	12.8
2015	7	27	10	43	24	33		0	0	0	0	0	0	66.6	0	0	13
2015	7	27	10	53	24	33		0	0	0	0	0	0	66.65	0	0	13
2015	7	27	11	3	24	32		0	0	0	0	0	0	66.69	0	0	13
2015	7	27	11	13	24	33		0	0	0	0	0	0	66.74	0	0	13
2015	7	27	11	23	24	32		0	0	0	0	0	0	66.79	0	0	12.8
2015	7	27	11	33	24	33		0	0	0	0	0	0	66.88	0	0	13
2015	7	27	11	43	24	33		0	0	0	0	0	0	66.92	0	0	13.2
2015	7	27	11	53	24	32		0	0	0	0	0	0	66.99	0	0	13.2
2015	7	27	12	3	24	32		0	0	0	0	0	0	67.05	0	0	13
2015	7	27	12	13	24	33		0	0	0	0	0	0	67.12	0	0	13
2015	7	27	12	23	24	32		0	0	0	0	0	0	67.19	0	0	13.2
2015	7	27	12	33	24	33		0	0	0	0	0	0	67.26	0	0	13.2
2015	7	27	12	43	24	32		0	0	0	0	0	0	67.35	0	0	13.2
2015	7	27	12	53	24	32		0	0	0	0	0	0	67.42	0	0	13.2
2015	7	27	13	3	24	33		0	0	0	0	0	0	67.5	0	0	13.2
2015	7	27	13	13	24	33		0	0	0	0	0	0	67.57	0	0	13
2015	7	27	13	23	24	33		0	0	0	0	0	0	67.57	0	0	13
2015	7	27	13	33	24	31		0	0	0	0	0	0	67.64	0	0	13
2015	7	27	13	43	24	32		0	0	0	0	0	0	67.71	0	0	13
2015	7	27	13	53	24	32		0	0	0	0	0	0	67.75	0	0	13
2015	7	27	14	3	24	32		0	0	0	0	0	0	67.82	0	0	13
2015	7	27	14	13	24	32		0	0	0	0	0	0	67.87	0	0	13
2015	7	27	14	23	24	32		0	0	0	0	0	0	67.93	0	0	13
2015	7	27	14	33	24	33		0	0	0	0	0	0	67.98	0	0	13
2015	7	27	14	43	24	32		0	0	0	0	0	0	68.02	0	0	13
2015	7	27	14	53	24	33		0	0	0	0	0	0	68.05	0	0	13
2015	7	27	15	3	24	32		0	0	0	0	0	0	68.13	0	0	13
2015	7	27	15	13	24	33		0	0	0	0	0	0	68.14	0	0	13
2015	7	27	15	23	24	33		0	0	0	0	0	0	68.18	0	0	12.8
2015	7	27	15	33	24	33		0	0	0	0	0	0	68.22	0	0	12.8
2015	7	27	15	43	24	31		0	0	0	0	0	0	68.25	0	0	12.8
2015	7	27	15	53	24	33		0	0	0	0	0	0	68.27	0	0	12.6
2015	7	27	16	3	24	32		0	0	0	0	0	0	68.29	0	0	12.6
2015	7	27	16	13	24	32		0	0	0	0	0	0	68.31	0	0	12.6
2015	7	27	16	23	24	33		0	0	0	0	0	0	68.32	0	0	12.6
2015	7	27	16	33	24	33		0	0	0	0	0	0	68.34	0	0	12.4
2015	7	27	16	43	24	32		0	0	0	0	0	0	68.36	0	0	12.4
2015	7	27	16	53	24	32		0	0	0	0	0	0	68.38	0	0	12.4
2015	7	27	17	3	24	32		0	0	0	0	0	0	68.38	0	0	12.2
2015	7	27	17	13	24	33		0	0	0	0	0	0	68.38	0	0	12.2
2015	7	27	17	23	24	32		0	0	0	0	0	0	68.38	0	0	12.2
2015	7	27	17	33	24	32		0	0	0	0	0	0	68.38	0	0	12
2015	7	27	17	43	24	33		0	0	0	0	0	0	68.38	0	0	12
2015	7	27	17	53	24	32		0	0	0	0	0	0	68.36	0	0	11.8
2015	7	27	18	3	24	32		0	0	0	0	0	0	68.36	0	0	11.8
2015	7	27	18	13	24	33		0	0	0	0	0	0	68.36	0	0	11.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	27	18	23	24	33		0	0	0	0	0	0	68.36	0	0	11.4
2015	7	27	18	33	24	33		0	0	0	0	0	0	68.36	0	0	11.6
2015	7	27	18	43	24	32		0	0	0	0	0	0	68.36	0	0	11.4
2015	7	27	18	53	24	32		0	0	0	0	0	0	68.36	0	0	11.4
2015	7	27	19	3	24	33		0	0	0	0	0	0	68.36	0	0	11.4
2015	7	27	19	13	24	32		0	0	0	0	0	0	68.36	0	0	11.4
2015	7	27	19	23	24	33		0	0	0	0	0	0	68.36	0	0	11.4
2015	7	27	19	33	24	33		0	0	0	0	0	0	68.34	0	0	11.4
2015	7	27	19	43	24	32		0	0	0	0	0	0	68.32	0	0	11.2
2015	7	27	19	53	24	32		0	0	0	0	0	0	68.31	0	0	11.8
2015	7	27	20	3	24	32		0	0	0	0	0	0	68.29	0	0	11.8
2015	7	27	20	13	24	32		0	0	0	0	0	0	68.29	0	0	11.8
2015	7	27	20	23	24	32		0	0	0	0	0	0	68.27	0	0	11.6
2015	7	27	20	33	24	32		0	0	0	0	0	0	68.23	0	0	11.8
2015	7	27	20	43	24	32		0	0	0	0	0	0	68.22	0	0	11.8
2015	7	27	20	53	24	32		0	0	0	0	0	0	68.22	0	0	11.8
2015	7	27	21	3	24	33		0	0	0	0	0	0	68.18	0	0	11.8
2015	7	27	21	13	24	32		0	0	0	0	0	0	68.16	0	0	11.8
2015	7	27	21	23	24	32		0	0	0	0	0	0	68.13	0	0	11.8
2015	7	27	21	33	24	32		0	0	0	0	0	0	68.11	0	0	11.8
2015	7	27	21	43	24	32		0	0	0	0	0	0	68.07	0	0	11.8
2015	7	27	21	53	24	32		0	0	0	0	0	0	68.04	0	0	11.8
2015	7	27	22	3	24	32		0	0	0	0	0	0	68	0	0	11.8
2015	7	27	22	13	24	32		0	0	0	0	0	0	67.96	0	0	11.8
2015	7	27	22	23	24	33		0	0	0	0	0	0	67.95	0	0	11.8
2015	7	27	22	33	24	32		0	0	0	0	0	0	67.89	0	0	11.8
2015	7	27	22	43	24	32		0	0	0	0	0	0	67.84	0	0	11.8
2015	7	27	22	53	24	32		0	0	0	0	0	0	67.8	0	0	11.8
2015	7	27	23	3	24	32		0	0	0	0	0	0	67.75	0	0	11.8
2015	7	27	23	13	24	32		0	0	0	0	0	0	67.71	0	0	11.8
2015	7	27	23	23	24	33		0	0	0	0	0	0	67.66	0	0	11.8
2015	7	27	23	33	24	32		0	0	0	0	0	0	67.62	0	0	11.8
2015	7	27	23	43	24	32		0	0	0	0	0	0	67.59	0	0	11.8
2015	7	27	23	53	24	33		0	0	0	0	0	0	67.53	0	0	11.8
2015	7	28	0	3	24	33		0	0	0	0	0	0	67.5	0	0	11.8
2015	7	28	0	13	24	32		0	0	0	0	0	0	67.46	0	0	11.8
2015	7	28	0	23	24	32		0	0	0	0	0	0	67.41	0	0	11.8
2015	7	28	0	33	24	33		0	0	0	0	0	0	67.37	0	0	11.8
2015	7	28	0	43	24	32		0	0	0	0	0	0	67.33	0	0	11.8
2015	7	28	0	53	24	33		0	0	0	0	0	0	67.3	0	0	11.8
2015	7	28	1	3	24	32		0	0	0	0	0	0	67.26	0	0	11.8
2015	7	28	1	13	24	33		0	0	0	0	0	0	67.23	0	0	11.8
2015	7	28	1	23	24	33		0	0	0	0	0	0	67.19	0	0	11.8
2015	7	28	1	33	24	33		0	0	0	0	0	0	67.15	0	0	11.8
2015	7	28	1	43	24	32		0	0	0	0	0	0	67.12	0	0	11.8
2015	7	28	1	53	24	33		0	0	0	0	0	0	67.08	0	0	11.8
2015	7	28	2	3	24	32		0	0	0	0	0	0	67.05	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	28	2	13	24	32		0	0	0	0	0	0	67.01	0	0	11.8
2015	7	28	2	23	24	33		0	0	0	0	0	0	66.97	0	0	11.8
2015	7	28	2	33	24	32		0	0	0	0	0	0	66.94	0	0	11.8
2015	7	28	2	43	24	32		0	0	0	0	0	0	66.9	0	0	11.8
2015	7	28	2	53	24	33		0	0	0	0	0	0	66.85	0	0	11.8
2015	7	28	3	3	24	32		0	0	0	0	0	0	66.81	0	0	11.6
2015	7	28	3	13	24	32		0	0	0	0	0	0	66.78	0	0	11.6
2015	7	28	3	23	24	31		0	0	0	0	0	0	66.74	0	0	11.6
2015	7	28	3	33	24	32		0	0	0	0	0	0	66.7	0	0	11.6
2015	7	28	3	43	24	33		0	0	0	0	0	0	66.65	0	0	11.6
2015	7	28	3	53	24	32		0	0	0	0	0	0	66.61	0	0	11.6
2015	7	28	4	3	24	33		0	0	0	0	0	0	66.58	0	0	11.6
2015	7	28	4	13	24	33		0	0	0	0	0	0	66.52	0	0	11.6
2015	7	28	4	23	24	33		0	0	0	0	0	0	66.47	0	0	11.6
2015	7	28	4	33	24	32		0	0	0	0	0	0	66.43	0	0	11.6
2015	7	28	4	43	24	33		0	0	0	0	0	0	66.4	0	0	11.6
2015	7	28	4	53	24	33		0	0	0	0	0	0	66.36	0	0	11.6
2015	7	28	5	3	24	32		0	0	0	0	0	0	66.31	0	0	11.6
2015	7	28	5	13	24	32		0	0	0	0	0	0	66.27	0	0	11.6
2015	7	28	5	23	24	33		0	0	0	0	0	0	66.22	0	0	11.6
2015	7	28	5	33	24	33		0	0	0	0	0	0	66.18	0	0	11.6
2015	7	28	5	43	24	33		0	0	0	0	0	0	66.13	0	0	11.6
2015	7	28	5	53	24	33		0	0	0	0	0	0	66.09	0	0	11.6
2015	7	28	6	3	24	33		0	0	0	0	0	0	66.06	0	0	11.6
2015	7	28	6	13	24	32		0	0	0	0	0	0	66	0	0	11.6
2015	7	28	6	23	24	32		0	0	0	0	0	0	65.97	0	0	11.6
2015	7	28	6	33	24	33		0	0	0	0	0	0	65.93	0	0	11.6
2015	7	28	6	43	24	33		0	0	0	0	0	0	65.88	0	0	11.6
2015	7	28	6	53	24	33		0	0	0	0	0	0	65.86	0	0	11.6
2015	7	28	7	3	24	32		0	0	0	0	0	0	65.82	0	0	11.8
2015	7	28	7	13	24	32		0	0	0	0	0	0	65.79	0	0	11.8
2015	7	28	7	23	24	32		0	0	0	0	0	0	65.75	0	0	11.8
2015	7	28	7	33	24	33		0	0	0	0	0	0	65.75	0	0	11.8
2015	7	28	7	43	24	33		0	0	0	0	0	0	65.75	0	0	12
2015	7	28	7	53	24	33		0	0	0	0	0	0	65.75	0	0	12
2015	7	28	8	3	24	32		0	0	0	0	0	0	65.75	0	0	12
2015	7	28	8	13	24	33		0	0	0	0	0	0	65.75	0	0	12
2015	7	28	8	23	24	33		0	0	0	0	0	0	65.77	0	0	12.2
2015	7	28	8	33	24	33		0	0	0	0	0	0	65.79	0	0	12.2
2015	7	28	8	43	24	33		0	0	0	0	0	0	65.8	0	0	12.4
2015	7	28	8	53	24	33		0	0	0	0	0	0	65.82	0	0	12.6
2015	7	28	9	3	24	33		0	0	0	0	0	0	65.84	0	0	12.6
2015	7	28	9	13	24	33		0	0	0	0	0	0	65.86	0	0	12.6
2015	7	28	9	23	24	33		0	0	0	0	0	0	65.89	0	0	13.4
2015	7	28	9	33	24	32		0	0	0	0	0	0	65.93	0	0	13.6
2015	7	28	9	43	24	32		0	0	0	0	0	0	65.97	0	0	13.6
2015	7	28	9	53	24	33		0	0	0	0	0	0	66	0	0	13.6

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	28	10	3	24	33	0	0	0	0	0	0	0	66.04	0	0	13.4
2015	7	28	10	13	24	32	0	0	0	0	0	0	0	66.09	0	0	13.6
2015	7	28	10	23	24	32	0	0	0	0	0	0	0	66.13	0	0	13.2
2015	7	28	10	33	24	33	0	0	0	0	0	0	0	66.2	0	0	13.4
2015	7	28	10	43	24	33	0	0	0	0	0	0	0	66.24	0	0	13.4
2015	7	28	10	53	24	33	0	0	0	0	0	0	0	66.31	0	0	13.2
2015	7	28	11	3	24	32	0	0	0	0	0	0	0	66.36	0	0	13.2
2015	7	28	11	13	24	32	0	0	0	0	0	0	0	66.42	0	0	12.8
2015	7	28	11	23	24	33	0	0	0	0	0	0	0	66.49	0	0	13.4
2015	7	28	11	33	24	33	0	0	0	0	0	0	0	66.56	0	0	13.4
2015	7	28	11	43	24	32	0	0	0	0	0	0	0	66.63	0	0	13.2
2015	7	28	11	53	24	33	0	0	0	0	0	0	0	66.7	0	0	13.2
2015	7	28	12	3	24	33	0	0	0	0	0	0	0	66.76	0	0	13
2015	7	28	12	13	24	33	0	0	0	0	0	0	0	66.81	0	0	13.2
2015	7	28	12	23	24	33	0	0	0	0	0	0	0	66.9	0	0	13.2
2015	7	28	12	33	24	33	0	0	0	0	0	0	0	66.96	0	0	13.4
2015	7	28	12	43	24	33	0	0	0	0	0	0	0	67.05	0	0	13.4
2015	7	28	12	53	24	32	0	0	0	0	0	0	0	67.1	0	0	13.4
2015	7	28	13	3	24	33	0	0	0	0	0	0	0	67.19	0	0	13.2
2015	7	28	13	13	24	32	0	0	0	0	0	0	0	67.24	0	0	13.2
2015	7	28	13	23	24	32	0	0	0	0	0	0	0	67.33	0	0	13.2
2015	7	28	13	33	24	33	0	0	0	0	0	0	0	67.39	0	0	13.2
2015	7	28	13	43	24	32	0	0	0	0	0	0	0	67.46	0	0	13
2015	7	28	13	53	24	33	0	0	0	0	0	0	0	67.5	0	0	13
2015	7	28	14	3	24	33	0	0	0	0	0	0	0	67.55	0	0	13
2015	7	28	14	13	24	32	0	0	0	0	0	0	0	67.62	0	0	13
2015	7	28	14	23	24	32	0	0	0	0	0	0	0	67.68	0	0	13
2015	7	28	14	33	24	32	0	0	0	0	0	0	0	67.73	0	0	13
2015	7	28	14	43	24	32	0	0	0	0	0	0	0	67.77	0	0	13
2015	7	28	14	53	24	33	0	0	0	0	0	0	0	67.84	0	0	12.8
2015	7	28	15	3	24	33	0	0	0	0	0	0	0	67.86	0	0	12.8
2015	7	28	15	13	24	33	0	0	0	0	0	0	0	67.93	0	0	12.8
2015	7	28	15	23	24	32	0	0	0	0	0	0	0	67.95	0	0	12.8
2015	7	28	15	33	24	32	0	0	0	0	0	0	0	67.96	0	0	12.8
2015	7	28	15	43	24	33	0	0	0	0	0	0	0	68.02	0	0	12.8
2015	7	28	15	53	24	32	0	0	0	0	0	0	0	68.04	0	0	12.8
2015	7	28	16	3	24	32	0	0	0	0	0	0	0	68.07	0	0	12.8
2015	7	28	16	13	24	32	0	0	0	0	0	0	0	68.09	0	0	12.8
2015	7	28	16	23	24	33	0	0	0	0	0	0	0	68.11	0	0	12.8
2015	7	28	16	33	24	32	0	0	0	0	0	0	0	68.11	0	0	12.6
2015	7	28	16	43	24	32	0	0	0	0	0	0	0	68.13	0	0	12.6
2015	7	28	16	53	24	32	0	0	0	0	0	0	0	68.14	0	0	12.6
2015	7	28	17	3	24	32	0	0	0	0	0	0	0	68.14	0	0	12.4
2015	7	28	17	13	24	32	0	0	0	0	0	0	0	68.16	0	0	12.4
2015	7	28	17	23	24	32	0	0	0	0	0	0	0	68.16	0	0	12.2
2015	7	28	17	33	24	32	0	0	0	0	0	0	0	68.16	0	0	12
2015	7	28	17	43	24	32	0	0	0	0	0	0	0	68.16	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	28	17	53	24	32		0	0	0	0	0	0	68.16	0	0	11.8
2015	7	28	18	3	24	32		0	0	0	0	0	0	68.14	0	0	11.6
2015	7	28	18	13	24	32		0	0	0	0	0	0	68.14	0	0	11.4
2015	7	28	18	23	24	32		0	0	0	0	0	0	68.14	0	0	11.4
2015	7	28	18	33	24	32		0	0	0	0	0	0	68.14	0	0	11.4
2015	7	28	18	43	24	32		0	0	0	0	0	0	68.16	0	0	11.4
2015	7	28	18	53	24	32		0	0	0	0	0	0	68.16	0	0	11.2
2015	7	28	19	3	24	32		0	0	0	0	0	0	68.18	0	0	11.2
2015	7	28	19	13	24	32		0	0	0	0	0	0	68.16	0	0	11.2
2015	7	28	19	23	24	33		0	0	0	0	0	0	68.16	0	0	11
2015	7	28	19	33	24	33		0	0	0	0	0	0	68.16	0	0	11.8
2015	7	28	19	43	24	32		0	0	0	0	0	0	68.14	0	0	11.8
2015	7	28	19	53	24	32		0	0	0	0	0	0	68.13	0	0	11.8
2015	7	28	20	3	24	32		0	0	0	0	0	0	68.11	0	0	11.8
2015	7	28	20	13	24	34		0	0	0	0	0	0	68.11	0	0	11
2015	7	28	20	23	24	32		0	0	0	0	0	0	68.09	0	0	11
2015	7	28	20	33	24	32		0	0	0	0	0	0	68.07	0	0	11.6
2015	7	28	20	43	24	32		0	0	0	0	0	0	68.05	0	0	11.6
2015	7	28	20	53	24	33		0	0	0	0	0	0	68.02	0	0	11.6
2015	7	28	21	3	24	33		0	0	0	0	0	0	68	0	0	11.6
2015	7	28	21	13	24	33		0	0	0	0	0	0	67.98	0	0	11.6
2015	7	28	21	23	24	32		0	0	0	0	0	0	67.95	0	0	11.6
2015	7	28	21	33	24	33		0	0	0	0	0	0	67.93	0	0	11
2015	7	28	21	43	24	33		0	0	0	0	0	0	67.89	0	0	11
2015	7	28	21	53	24	32		0	0	0	0	0	0	67.86	0	0	11
2015	7	28	22	3	24	33		0	0	0	0	0	0	67.82	0	0	10.8
2015	7	28	22	13	24	32		0	0	0	0	0	0	67.77	0	0	10.8
2015	7	28	22	23	24	33		0	0	0	0	0	0	67.75	0	0	10.8
2015	7	28	22	33	24	33		0	0	0	0	0	0	67.69	0	0	11
2015	7	28	22	43	24	32		0	0	0	0	0	0	67.66	0	0	11
2015	7	28	22	53	24	32		0	0	0	0	0	0	67.62	0	0	10.8
2015	7	28	23	3	24	32		0	0	0	0	0	0	67.59	0	0	10.8
2015	7	28	23	13	24	33		0	0	0	0	0	0	67.53	0	0	10.8
2015	7	28	23	23	24	32		0	0	0	0	0	0	67.5	0	0	10.8
2015	7	28	23	33	24	32		0	0	0	0	0	0	67.44	0	0	11
2015	7	28	23	43	24	32		0	0	0	0	0	0	67.41	0	0	11
2015	7	28	23	53	24	33		0	0	0	0	0	0	67.35	0	0	11
2015	7	29	0	3	24	33		0	0	0	0	0	0	67.32	0	0	11
2015	7	29	0	13	24	33		0	0	0	0	0	0	67.26	0	0	11
2015	7	29	0	23	24	32		0	0	0	0	0	0	67.23	0	0	11
2015	7	29	0	33	24	32		0	0	0	0	0	0	67.17	0	0	10.8
2015	7	29	0	43	24	32		0	0	0	0	0	0	67.12	0	0	10.8
2015	7	29	0	53	24	32		0	0	0	0	0	0	67.06	0	0	10.8
2015	7	29	1	3	24	32		0	0	0	0	0	0	67.03	0	0	10.8
2015	7	29	1	13	24	33		0	0	0	0	0	0	66.97	0	0	10.8
2015	7	29	1	23	24	33		0	0	0	0	0	0	66.94	0	0	10.8
2015	7	29	1	33	24	33		0	0	0	0	0	0	66.9	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	29	1	43	24	32		0	0	0	0	0	0	66.87	0	0	11.8
2015	7	29	1	53	24	32		0	0	0	0	0	0	66.83	0	0	11.8
2015	7	29	2	3	24	33		0	0	0	0	0	0	66.76	0	0	11.8
2015	7	29	2	13	24	32		0	0	0	0	0	0	66.72	0	0	11.8
2015	7	29	2	23	24	33		0	0	0	0	0	0	66.67	0	0	11.8
2015	7	29	2	33	24	32		0	0	0	0	0	0	66.63	0	0	11.6
2015	7	29	2	43	24	32		0	0	0	0	0	0	66.58	0	0	11.6
2015	7	29	2	53	24	33		0	0	0	0	0	0	66.52	0	0	11.6
2015	7	29	3	3	24	33		0	0	0	0	0	0	66.47	0	0	11.6
2015	7	29	3	13	24	33		0	0	0	0	0	0	66.42	0	0	11.6
2015	7	29	3	23	24	33		0	0	0	0	0	0	66.36	0	0	11.6
2015	7	29	3	33	24	33		0	0	0	0	0	0	66.33	0	0	11.6
2015	7	29	3	43	24	32		0	0	0	0	0	0	66.25	0	0	11.6
2015	7	29	3	53	24	33		0	0	0	0	0	0	66.22	0	0	11.6
2015	7	29	4	3	24	33		0	0	0	0	0	0	66.16	0	0	11.6
2015	7	29	4	13	24	32		0	0	0	0	0	0	66.11	0	0	11.6
2015	7	29	4	23	24	33		0	0	0	0	0	0	66.07	0	0	11.6
2015	7	29	4	33	24	33		0	0	0	0	0	0	66.02	0	0	11.6
2015	7	29	4	43	24	33		0	0	0	0	0	0	65.98	0	0	11.6
2015	7	29	4	53	24	32		0	0	0	0	0	0	65.93	0	0	11.6
2015	7	29	5	3	24	33		0	0	0	0	0	0	65.88	0	0	11.6
2015	7	29	5	13	24	33		0	0	0	0	0	0	65.82	0	0	11.6
2015	7	29	5	23	24	32		0	0	0	0	0	0	65.77	0	0	11.6
2015	7	29	5	33	24	33		0	0	0	0	0	0	65.73	0	0	11.6
2015	7	29	5	43	24	33		0	0	0	0	0	0	65.68	0	0	11.6
2015	7	29	5	53	24	34		0	0	0	0	0	0	65.62	0	0	11.6
2015	7	29	6	3	24	33		0	0	0	0	0	0	65.59	0	0	11.6
2015	7	29	6	13	24	33		0	0	0	0	0	0	65.53	0	0	11.6
2015	7	29	6	23	24	33		0	0	0	0	0	0	65.48	0	0	11.6
2015	7	29	6	33	24	33		0	0	0	0	0	0	65.44	0	0	11.6
2015	7	29	6	43	24	33		0	0	0	0	0	0	65.41	0	0	11.6
2015	7	29	6	53	24	33		0	0	0	0	0	0	65.35	0	0	11.6
2015	7	29	7	3	24	33		0	0	0	0	0	0	65.32	0	0	11.8
2015	7	29	7	13	24	33		0	0	0	0	0	0	65.3	0	0	11.8
2015	7	29	7	23	24	33		0	0	0	0	0	0	65.26	0	0	11.8
2015	7	29	7	33	24	33		0	0	0	0	0	0	65.26	0	0	11.8
2015	7	29	7	43	24	33		0	0	0	0	0	0	65.26	0	0	12
2015	7	29	7	53	24	33		0	0	0	0	0	0	65.25	0	0	12
2015	7	29	8	3	24	32		0	0	0	0	0	0	65.26	0	0	12
2015	7	29	8	13	24	32		0	0	0	0	0	0	65.26	0	0	13.2
2015	7	29	8	23	24	33		0	0	0	0	0	0	65.28	0	0	13
2015	7	29	8	33	24	32		0	0	0	0	0	0	65.28	0	0	12.2
2015	7	29	8	43	24	33		0	0	0	0	0	0	65.3	0	0	13
2015	7	29	8	53	24	32		0	0	0	0	0	0	65.34	0	0	13
2015	7	29	9	3	24	32		0	0	0	0	0	0	65.37	0	0	13
2015	7	29	9	13	24	32		0	0	0	0	0	0	65.39	0	0	13
2015	7	29	9	23	24	32		0	0	0	0	0	0	65.43	0	0	13

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	29	9	33	24	33		0	0	0	0	0	0	65.46	0	0	13
2015	7	29	9	43	24	32		0	0	0	0	0	0	65.52	0	0	13
2015	7	29	9	53	24	33		0	0	0	0	0	0	65.55	0	0	13
2015	7	29	10	3	24	32		0	0	0	0	0	0	65.61	0	0	13
2015	7	29	10	13	24	32		0	0	0	0	0	0	65.66	0	0	12.8
2015	7	29	10	23	24	33		0	0	0	0	0	0	65.73	0	0	12.8
2015	7	29	10	33	24	32		0	0	0	0	0	0	65.79	0	0	13.2
2015	7	29	10	43	24	33		0	0	0	0	0	0	65.86	0	0	13.2
2015	7	29	10	53	24	33		0	0	0	0	0	0	65.93	0	0	13
2015	7	29	11	3	24	33		0	0	0	0	0	0	65.98	0	0	13
2015	7	29	11	13	24	32		0	0	0	0	0	0	66.06	0	0	13
2015	7	29	11	23	24	32		0	0	0	0	0	0	66.13	0	0	13
2015	7	29	11	33	24	33		0	0	0	0	0	0	66.2	0	0	13
2015	7	29	11	43	24	32		0	0	0	0	0	0	66.25	0	0	13
2015	7	29	11	53	24	32		0	0	0	0	0	0	66.33	0	0	13
2015	7	29	12	3	24	32		0	0	0	0	0	0	66.4	0	0	13
2015	7	29	12	13	24	33		0	0	0	0	0	0	66.47	0	0	13
2015	7	29	12	23	24	33		0	0	0	0	0	0	66.54	0	0	13
2015	7	29	12	33	24	33		0	0	0	0	0	0	66.61	0	0	13
2015	7	29	12	43	24	32		0	0	0	0	0	0	66.69	0	0	13
2015	7	29	12	53	24	32		0	0	0	0	0	0	66.78	0	0	13
2015	7	29	13	3	24	33		0	0	0	0	0	0	66.85	0	0	13
2015	7	29	13	13	24	32		0	0	0	0	0	0	66.9	0	0	13
2015	7	29	13	23	24	32		0	0	0	0	0	0	66.96	0	0	13
2015	7	29	13	33	24	32		0	0	0	0	0	0	67.03	0	0	13.2
2015	7	29	13	43	24	32		0	0	0	0	0	0	67.1	0	0	13.2
2015	7	29	13	53	24	32		0	0	0	0	0	0	67.14	0	0	13.2
2015	7	29	14	3	24	33		0	0	0	0	0	0	67.19	0	0	13
2015	7	29	14	13	24	33		0	0	0	0	0	0	67.26	0	0	13
2015	7	29	14	23	24	33		0	0	0	0	0	0	67.33	0	0	12.8
2015	7	29	14	33	24	33		0	0	0	0	0	0	67.35	0	0	13.2
2015	7	29	14	43	24	32		0	0	0	0	0	0	67.41	0	0	12.8
2015	7	29	14	53	24	32		0	0	0	0	0	0	67.46	0	0	12.8
2015	7	29	15	3	24	33		0	0	0	0	0	0	67.5	0	0	12.8
2015	7	29	15	13	24	33		0	0	0	0	0	0	67.55	0	0	12.8
2015	7	29	15	23	24	33		0	0	0	0	0	0	67.57	0	0	12.8
2015	7	29	15	33	24	33		0	0	0	0	0	0	67.6	0	0	13
2015	7	29	15	43	24	33		0	0	0	0	0	0	67.64	0	0	13
2015	7	29	15	53	24	32		0	0	0	0	0	0	67.68	0	0	12.6
2015	7	29	16	3	24	32		0	0	0	0	0	0	67.69	0	0	12.6
2015	7	29	16	13	24	32		0	0	0	0	0	0	67.71	0	0	12.6
2015	7	29	16	23	24	33		0	0	0	0	0	0	67.73	0	0	12.6
2015	7	29	16	33	24	32		0	0	0	0	0	0	67.75	0	0	12.4
2015	7	29	16	43	24	32		0	0	0	0	0	0	67.75	0	0	12.4
2015	7	29	16	53	24	33		0	0	0	0	0	0	67.77	0	0	12.4
2015	7	29	17	3	24	32		0	0	0	0	0	0	67.78	0	0	12.4
2015	7	29	17	13	24	32		0	0	0	0	0	0	67.78	0	0	12.2

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	29	17	23	24	33		0	0	0	0	0	0	67.8	0	0	12.2
2015	7	29	17	33	24	33		0	0	0	0	0	0	67.78	0	0	12
2015	7	29	17	43	24	32		0	0	0	0	0	0	67.8	0	0	12
2015	7	29	17	53	24	32		0	0	0	0	0	0	67.78	0	0	11.8
2015	7	29	18	3	24	33		0	0	0	0	0	0	67.78	0	0	11.6
2015	7	29	18	13	24	31		0	0	0	0	0	0	67.78	0	0	11.4
2015	7	29	18	23	24	32		0	0	0	0	0	0	67.8	0	0	11.2
2015	7	29	18	33	24	32		0	0	0	0	0	0	67.8	0	0	11.2
2015	7	29	18	43	24	33		0	0	0	0	0	0	67.78	0	0	11.2
2015	7	29	18	53	24	33		0	0	0	0	0	0	67.78	0	0	11
2015	7	29	19	3	24	32		0	0	0	0	0	0	67.78	0	0	11
2015	7	29	19	13	24	33		0	0	0	0	0	0	67.8	0	0	11
2015	7	29	19	23	24	32		0	0	0	0	0	0	67.8	0	0	11
2015	7	29	19	33	24	32		0	0	0	0	0	0	67.8	0	0	11
2015	7	29	19	43	24	32		0	0	0	0	0	0	67.82	0	0	10.8
2015	7	29	19	53	24	32		0	0	0	0	0	0	67.82	0	0	10.8
2015	7	29	20	3	24	32		0	0	0	0	0	0	67.82	0	0	10.8
2015	7	29	20	13	24	33		0	0	0	0	0	0	67.82	0	0	10.8
2015	7	29	20	23	24	33		0	0	0	0	0	0	67.8	0	0	10.8
2015	7	29	20	33	24	32		0	0	0	0	0	0	67.8	0	0	10.6
2015	7	29	20	43	24	32		0	0	0	0	0	0	67.8	0	0	10.4
2015	7	29	20	53	24	32		0	0	0	0	0	0	67.78	0	0	10.4
2015	7	29	21	3	24	32		0	0	0	0	0	0	67.77	0	0	10.4
2015	7	29	21	13	24	33		0	0	0	0	0	0	67.77	0	0	10.2
2015	7	29	21	23	24	32		0	0	0	0	0	0	67.75	0	0	10.2
2015	7	29	21	33	24	32		0	0	0	0	0	0	67.73	0	0	10.4
2015	7	29	21	43	24	32		0	0	0	0	0	0	67.73	0	0	10.2
2015	7	29	21	53	24	32		0	0	0	0	0	0	67.71	0	0	10.2
2015	7	29	22	3	24	32		0	0	0	0	0	0	67.69	0	0	10.2
2015	7	29	22	13	24	32		0	0	0	0	0	0	67.68	0	0	10
2015	7	29	22	23	24	32		0	0	0	0	0	0	67.68	0	0	10
2015	7	29	22	33	24	33		0	0	0	0	0	0	67.66	0	0	10.6
2015	7	29	22	43	24	32		0	0	0	0	0	0	67.64	0	0	10.4
2015	7	29	22	53	24	32		0	0	0	0	0	0	67.62	0	0	10.4
2015	7	29	23	3	24	33		0	0	0	0	0	0	67.6	0	0	10.2
2015	7	29	23	13	24	33		0	0	0	0	0	0	67.59	0	0	10.4
2015	7	29	23	23	24	33		0	0	0	0	0	0	67.59	0	0	10.2
2015	7	29	23	33	24	32		0	0	0	0	0	0	67.57	0	0	10.6
2015	7	29	23	43	24	33		0	0	0	0	0	0	67.57	0	0	10.6
2015	7	29	23	53	24	33		0	0	0	0	0	0	67.55	0	0	10.4
2015	7	30	0	3	24	32		0	0	0	0	0	0	67.53	0	0	10.4
2015	7	30	0	13	24	32		0	0	0	0	0	0	67.51	0	0	10.4
2015	7	30	0	23	24	32		0	0	0	0	0	0	67.51	0	0	10.4
2015	7	30	0	33	24	33		0	0	0	0	0	0	67.5	0	0	10.6
2015	7	30	0	43	24	33		0	0	0	0	0	0	67.48	0	0	10.6
2015	7	30	0	53	24	32		0	0	0	0	0	0	67.46	0	0	10.4
2015	7	30	1	3	24	32		0	0	0	0	0	0	67.44	0	0	10.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	30	1	13	24	32		0	0	0	0	0	0	67.44	0	0	10.4
2015	7	30	1	23	24	32		0	0	0	0	0	0	67.42	0	0	10.4
2015	7	30	1	33	24	33		0	0	0	0	0	0	67.41	0	0	10.6
2015	7	30	1	43	24	32		0	0	0	0	0	0	67.39	0	0	11
2015	7	30	1	53	24	32		0	0	0	0	0	0	67.37	0	0	11
2015	7	30	2	3	24	32		0	0	0	0	0	0	67.35	0	0	10.8
2015	7	30	2	13	24	32		0	0	0	0	0	0	67.33	0	0	10.8
2015	7	30	2	23	24	33		0	0	0	0	0	0	67.33	0	0	10.6
2015	7	30	2	33	24	33		0	0	0	0	0	0	67.32	0	0	10.6
2015	7	30	2	43	24	33		0	0	0	0	0	0	67.3	0	0	10.6
2015	7	30	2	53	24	33		0	0	0	0	0	0	67.26	0	0	10.6
2015	7	30	3	3	24	33		0	0	0	0	0	0	67.24	0	0	10.4
2015	7	30	3	13	24	33		0	0	0	0	0	0	67.23	0	0	10.4
2015	7	30	3	23	24	33		0	0	0	0	0	0	67.19	0	0	10.4
2015	7	30	3	33	24	33		0	0	0	0	0	0	67.17	0	0	10.6
2015	7	30	3	43	24	32		0	0	0	0	0	0	67.14	0	0	10.4
2015	7	30	3	53	24	32		0	0	0	0	0	0	67.1	0	0	10.2
2015	7	30	4	3	24	33		0	0	0	0	0	0	67.08	0	0	10.4
2015	7	30	4	13	24	32		0	0	0	0	0	0	67.05	0	0	10.4
2015	7	30	4	23	24	33		0	0	0	0	0	0	67.01	0	0	10.2
2015	7	30	4	33	24	32		0	0	0	0	0	0	66.99	0	0	10.6
2015	7	30	4	43	24	33		0	0	0	0	0	0	66.96	0	0	10.6
2015	7	30	4	53	24	33		0	0	0	0	0	0	66.92	0	0	10.6
2015	7	30	5	3	24	32		0	0	0	0	0	0	66.88	0	0	10.6
2015	7	30	5	13	24	33		0	0	0	0	0	0	66.87	0	0	10.4
2015	7	30	5	23	24	33		0	0	0	0	0	0	66.83	0	0	10.4
2015	7	30	5	33	24	33		0	0	0	0	0	0	66.79	0	0	10.8
2015	7	30	5	43	24	33		0	0	0	0	0	0	66.78	0	0	11.6
2015	7	30	5	53	24	32		0	0	0	0	0	0	66.74	0	0	11.6
2015	7	30	6	3	24	32		0	0	0	0	0	0	66.72	0	0	11.6
2015	7	30	6	13	24	32		0	0	0	0	0	0	66.7	0	0	11.6
2015	7	30	6	23	24	33		0	0	0	0	0	0	66.67	0	0	11.6
2015	7	30	6	33	24	33		0	0	0	0	0	0	66.65	0	0	11.6
2015	7	30	6	43	24	32		0	0	0	0	0	0	66.61	0	0	11.6
2015	7	30	6	53	24	32		0	0	0	0	0	0	66.6	0	0	11.6
2015	7	30	7	3	24	32		0	0	0	0	0	0	66.58	0	0	11.6
2015	7	30	7	13	24	32		0	0	0	0	0	0	66.58	0	0	11.6
2015	7	30	7	23	24	32		0	0	0	0	0	0	66.56	0	0	11.6
2015	7	30	7	33	24	33		0	0	0	0	0	0	66.56	0	0	11.8
2015	7	30	8	1	37	32		0	0	0	0	0	0	66.56	0	0	11.8
2015	7	30	8	23	16	32		0	0	0	0	0	0	66.58	0	0	11.8
2015	7	30	8	33	16	33		0	0	0	0	0	0	66.61	0	0	11.8
2015	7	30	8	43	16	33		0	0	0	0	0	0	66.63	0	0	12
2015	7	30	8	53	16	32		0	0	0	0	0	0	66.65	0	0	12
2015	7	30	9	3	16	33		0	0	0	0	0	0	66.79	0	0	12.2
2015	7	30	9	13	16	33		0	0	0	0	0	0	66.74	0	0	12
2015	7	30	9	23	16	32		0	0	0	0	0	0	66.7	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	30	9	33	16	32		0	0	0	0	0	0	66.72	0	0	12
2015	7	30	9	43	16	32		0	0	0	0	0	0	66.76	0	0	12
2015	7	30	9	53	16	33		0	0	0	0	0	0	66.78	0	0	12
2015	7	30	10	3	16	32		0	0	0	0	0	0	66.79	0	0	12
2015	7	30	10	13	16	33		0	0	0	0	0	0	66.88	0	0	12.2
2015	7	30	10	23	16	33		0	0	0	0	0	0	66.94	0	0	12.2
2015	7	30	10	33	16	32		0	0	0	0	0	0	67.01	0	0	12.2
2015	7	30	10	43	16	32		0	0	0	0	0	0	67.1	0	0	12.4
2015	7	30	10	53	16	32		0	0	0	0	0	0	67.17	0	0	12.4
2015	7	30	11	3	16	33		0	0	0	0	0	0	67.08	0	0	12.2
2015	7	30	11	13	16	32		0	0	0	0	0	0	67.06	0	0	12.2
2015	7	30	11	23	16	32		0	0	0	0	0	0	67.12	0	0	12.2
2015	7	30	11	33	16	32		0	0	0	0	0	0	67.17	0	0	12.2
2015	7	30	11	43	16	33		0	0	0	0	0	0	67.19	0	0	12.2
2015	7	30	11	53	16	32		0	0	0	0	0	0	67.21	0	0	12.2
2015	7	30	12	3	16	32		0	0	0	0	0	0	67.24	0	0	12.2
2015	7	30	12	13	16	32		0	0	0	0	0	0	67.32	0	0	12.4
2015	7	30	12	23	16	32		0	0	0	0	0	0	67.39	0	0	12.4
2015	7	30	12	33	16	33		0	0	0	0	0	0	67.37	0	0	12.2
2015	7	30	12	43	16	32		0	0	0	0	0	0	67.5	0	0	12.4
2015	7	30	12	53	16	33		0	0	0	0	0	0	67.6	0	0	12.4
2015	7	30	13	3	16	33		0	0	0	0	0	0	67.62	0	0	12.4
2015	7	30	13	13	16	33		0	0	0	0	0	0	67.6	0	0	12.4
2015	7	30	13	23	16	32		0	0	0	0	0	0	67.68	0	0	12.4
2015	7	30	13	33	16	32		0	0	0	0	0	0	67.68	0	0	12.2
2015	7	30	13	43	16	32		0	0	0	0	0	0	67.71	0	0	12.4
2015	7	30	13	53	16	32		0	0	0	0	0	0	67.91	0	0	12.6
2015	7	30	14	3	16	32		0	0	0	0	0	0	67.91	0	0	12.4
2015	7	30	14	13	16	32		0	0	0	0	0	0	67.91	0	0	12.4
2015	7	30	14	23	16	32		0	0	0	0	0	0	68.05	0	0	12.6
2015	7	30	14	33	16	33		0	0	0	0	0	0	68.16	0	0	12.6
2015	7	30	14	43	16	32		0	0	0	0	0	0	68.23	0	0	12.6
2015	7	30	14	53	16	33		0	0	0	0	0	0	68.16	0	0	12.4
2015	7	30	15	3	16	32		0	0	0	0	0	0	68.14	0	0	12.4
2015	7	30	15	13	16	31		0	0	0	0	0	0	68.22	0	0	12.4
2015	7	30	15	23	16	32		0	0	0	0	0	0	68.18	0	0	12.4
2015	7	30	15	33	16	32		0	0	0	0	0	0	68.14	0	0	12.2
2015	7	30	15	43	16	32		0	0	0	0	0	0	68.13	0	0	12.2
2015	7	30	15	53	16	32		0	0	0	0	0	0	68.13	0	0	12.2
2015	7	30	16	3	16	32		0	0	0	0	0	0	68.13	0	0	12.2
2015	7	30	16	13	16	33		0	0	0	0	0	0	68.16	0	0	12.2
2015	7	30	16	23	16	32		0	0	0	0	0	0	68.18	0	0	12.2
2015	7	30	16	33	16	32		0	0	0	0	0	0	68.22	0	0	12.2
2015	7	30	16	43	16	33		0	0	0	0	0	0	68.23	0	0	12.2
2015	7	30	16	53	16	32		0	0	0	0	0	0	68.23	0	0	12
2015	7	30	17	3	16	32		0	0	0	0	0	0	68.25	0	0	12
2015	7	30	17	13	16	32		0	0	0	0	0	0	68.25	0	0	12

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	30	17	23	16	32		0	0	0	0	0	0	68.25	0	0	12
2015	7	30	17	33	16	33		0	0	0	0	0	0	68.27	0	0	12
2015	7	30	17	43	16	32		0	0	0	0	0	0	68.27	0	0	12
2015	7	30	17	53	16	32		0	0	0	0	0	0	68.29	0	0	12
2015	7	30	18	3	16	32		0	0	0	0	0	0	68.29	0	0	12
2015	7	30	18	13	16	32		0	0	0	0	0	0	68.31	0	0	12
2015	7	30	18	23	16	32		0	0	0	0	0	0	68.31	0	0	12
2015	7	30	18	33	16	32		0	0	0	0	0	0	68.31	0	0	12
2015	7	30	18	43	16	32		0	0	0	0	0	0	68.32	0	0	12
2015	7	30	18	53	16	32		0	0	0	0	0	0	68.32	0	0	12
2015	7	30	19	3	16	33		0	0	0	0	0	0	68.32	0	0	12
2015	7	30	19	13	16	32		0	0	0	0	0	0	68.32	0	0	12
2015	7	30	19	23	16	32		0	0	0	0	0	0	68.31	0	0	12
2015	7	30	19	33	16	32		0	0	0	0	0	0	68.31	0	0	11.8
2015	7	30	19	43	16	33		0	0	0	0	0	0	68.29	0	0	11.8
2015	7	30	19	53	16	32		0	0	0	0	0	0	68.29	0	0	11.8
2015	7	30	20	3	16	32		0	0	0	0	0	0	68.27	0	0	11.8
2015	7	30	20	13	16	32		0	0	0	0	0	0	68.25	0	0	11.8
2015	7	30	20	23	16	32		0	0	0	0	0	0	68.23	0	0	11.8
2015	7	30	20	33	16	32		0	0	0	0	0	0	68.23	0	0	11.8
2015	7	30	20	43	16	33		0	0	0	0	0	0	68.23	0	0	11.8
2015	7	30	20	53	16	32		0	0	0	0	0	0	68.22	0	0	11.8
2015	7	30	21	3	16	32		0	0	0	0	0	0	68.2	0	0	11.8
2015	7	30	21	13	16	32		0	0	0	0	0	0	68.18	0	0	11.8
2015	7	30	21	23	16	32		0	0	0	0	0	0	68.16	0	0	11.8
2015	7	30	21	33	16	33		0	0	0	0	0	0	68.14	0	0	11.8
2015	7	30	21	43	16	33		0	0	0	0	0	0	68.13	0	0	11.8
2015	7	30	21	53	16	32		0	0	0	0	0	0	68.13	0	0	11.8
2015	7	30	22	3	16	32		0	0	0	0	0	0	68.11	0	0	11.8
2015	7	30	22	13	16	34		0	0	0	0	0	0	68.09	0	0	11.8
2015	7	30	22	23	16	33		0	0	0	0	0	0	68.05	0	0	11.8
2015	7	30	22	33	16	33		0	0	0	0	0	0	68.04	0	0	11.8
2015	7	30	22	43	16	33		0	0	0	0	0	0	68.02	0	0	11.8
2015	7	30	22	53	16	32		0	0	0	0	0	0	68	0	0	11.8
2015	7	30	23	3	16	32		0	0	0	0	0	0	67.98	0	0	11.8
2015	7	30	23	13	16	33		0	0	0	0	0	0	67.96	0	0	11.8
2015	7	30	23	23	16	33		0	0	0	0	0	0	67.93	0	0	11.8
2015	7	30	23	33	16	33		0	0	0	0	0	0	67.91	0	0	11.8
2015	7	30	23	43	16	32		0	0	0	0	0	0	67.89	0	0	11.8
2015	7	30	23	53	16	32		0	0	0	0	0	0	67.87	0	0	11.8
2015	7	31	0	3	16	32		0	0	0	0	0	0	67.86	0	0	11.8
2015	7	31	0	13	16	32		0	0	0	0	0	0	67.84	0	0	11.8
2015	7	31	0	23	16	32		0	0	0	0	0	0	67.82	0	0	11.8
2015	7	31	0	33	16	32		0	0	0	0	0	0	67.8	0	0	11.8
2015	7	31	0	43	16	33		0	0	0	0	0	0	67.78	0	0	11.8
2015	7	31	0	53	16	32		0	0	0	0	0	0	67.75	0	0	11.8
2015	7	31	1	3	16	32		0	0	0	0	0	0	67.73	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	31	1	13	16	33		0	0	0	0	0	0	67.71	0	0	11.8
2015	7	31	1	23	16	32		0	0	0	0	0	0	67.69	0	0	11.8
2015	7	31	1	33	16	32		0	0	0	0	0	0	67.68	0	0	11.8
2015	7	31	1	43	16	32		0	0	0	0	0	0	67.66	0	0	11.8
2015	7	31	1	53	16	32		0	0	0	0	0	0	67.64	0	0	11.8
2015	7	31	2	3	16	32		0	0	0	0	0	0	67.62	0	0	11.8
2015	7	31	2	13	16	32		0	0	0	0	0	0	67.6	0	0	11.8
2015	7	31	2	23	16	32		0	0	0	0	0	0	67.59	0	0	11.8
2015	7	31	2	33	16	33		0	0	0	0	0	0	67.59	0	0	11.8
2015	7	31	2	43	16	33		0	0	0	0	0	0	67.57	0	0	11.8
2015	7	31	2	53	16	33		0	0	0	0	0	0	67.55	0	0	11.8
2015	7	31	3	3	16	33		0	0	0	0	0	0	67.55	0	0	11.8
2015	7	31	3	13	16	33		0	0	0	0	0	0	67.53	0	0	11.8
2015	7	31	3	23	16	33		0	0	0	0	0	0	67.51	0	0	11.8
2015	7	31	3	33	16	32		0	0	0	0	0	0	67.5	0	0	11.8
2015	7	31	3	43	16	33		0	0	0	0	0	0	67.48	0	0	11.8
2015	7	31	3	53	16	32		0	0	0	0	0	0	67.46	0	0	11.8
2015	7	31	4	3	16	33		0	0	0	0	0	0	67.44	0	0	11.8
2015	7	31	4	13	16	32		0	0	0	0	0	0	67.44	0	0	11.8
2015	7	31	4	23	16	33		0	0	0	0	0	0	67.41	0	0	11.8
2015	7	31	4	33	16	33		0	0	0	0	0	0	67.41	0	0	11.8
2015	7	31	4	43	16	33		0	0	0	0	0	0	67.39	0	0	11.8
2015	7	31	4	53	16	33		0	0	0	0	0	0	67.37	0	0	11.8
2015	7	31	5	3	16	32		0	0	0	0	0	0	67.37	0	0	11.8
2015	7	31	5	13	16	33		0	0	0	0	0	0	67.35	0	0	11.8
2015	7	31	5	23	16	33		0	0	0	0	0	0	67.33	0	0	11.8
2015	7	31	5	33	16	32		0	0	0	0	0	0	67.32	0	0	11.8
2015	7	31	5	43	16	32		0	0	0	0	0	0	67.32	0	0	11.8
2015	7	31	5	53	16	32		0	0	0	0	0	0	67.28	0	0	11.8
2015	7	31	6	3	16	32		0	0	0	0	0	0	67.28	0	0	11.8
2015	7	31	6	13	16	32		0	0	0	0	0	0	67.26	0	0	11.8
2015	7	31	6	23	16	32		0	0	0	0	0	0	67.26	0	0	11.8
2015	7	31	6	33	16	32		0	0	0	0	0	0	67.24	0	0	11.8
2015	7	31	6	43	16	32		0	0	0	0	0	0	67.24	0	0	11.8
2015	7	31	6	53	16	33		0	0	0	0	0	0	67.23	0	0	11.8
2015	7	31	7	3	16	33		0	0	0	0	0	0	67.23	0	0	11.8
2015	7	31	7	13	16	33		0	0	0	0	0	0	67.23	0	0	11.8
2015	7	31	7	23	16	32		0	0	0	0	0	0	67.21	0	0	11.8
2015	7	31	7	33	16	33		0	0	0	0	0	0	67.21	0	0	11.8
2015	7	31	7	43	16	32		0	0	0	0	0	0	67.19	0	0	11.8
2015	7	31	7	53	16	32		0	0	0	0	0	0	67.19	0	0	11.8
2015	7	31	8	3	16	32		0	0	0	0	0	0	67.21	0	0	11.8
2015	7	31	8	13	16	33		0	0	0	0	0	0	67.19	0	0	11.8
2015	7	31	8	23	16	32		0	0	0	0	0	0	67.19	0	0	11.8
2015	7	31	8	33	16	32		0	0	0	0	0	0	67.19	0	0	11.8
2015	7	31	8	43	16	33		0	0	0	0	0	0	67.19	0	0	11.8
2015	7	31	8	53	16	32		0	0	0	0	0	0	67.21	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	31	9	3	16	32		0	0	0	0	0	0	67.21	0	0	11.8
2015	7	31	9	13	16	32		0	0	0	0	0	0	67.23	0	0	11.8
2015	7	31	9	23	16	32		0	0	0	0	0	0	67.23	0	0	11.8
2015	7	31	9	33	16	33		0	0	0	0	0	0	67.24	0	0	11.8
2015	7	31	9	43	16	33		0	0	0	0	0	0	67.26	0	0	11.8
2015	7	31	9	53	16	33		0	0	0	0	0	0	67.28	0	0	11.8
2015	7	31	10	3	16	32		0	0	0	0	0	0	67.3	0	0	12
2015	7	31	10	13	16	32		0	0	0	0	0	0	67.33	0	0	12
2015	7	31	10	23	16	32		0	0	0	0	0	0	67.39	0	0	12
2015	7	31	10	33	16	32		0	0	0	0	0	0	67.42	0	0	12
2015	7	31	10	43	16	32		0	0	0	0	0	0	67.41	0	0	12
2015	7	31	10	53	16	32		0	0	0	0	0	0	67.42	0	0	12
2015	7	31	11	3	16	33		0	0	0	0	0	0	67.44	0	0	12
2015	7	31	11	13	16	32		0	0	0	0	0	0	67.48	0	0	12.2
2015	7	31	11	23	16	32		0	0	0	0	0	0	67.5	0	0	12.2
2015	7	31	11	33	16	32		0	0	0	0	0	0	67.51	0	0	12
2015	7	31	11	43	16	32		0	0	0	0	0	0	67.55	0	0	12.2
2015	7	31	11	53	16	32		0	0	0	0	0	0	67.55	0	0	12.2
2015	7	31	12	3	16	32		0	0	0	0	0	0	67.57	0	0	12.2
2015	7	31	12	13	16	32		0	0	0	0	0	0	67.6	0	0	12.2
2015	7	31	12	23	16	33		0	0	0	0	0	0	67.64	0	0	12.2
2015	7	31	12	33	16	33		0	0	0	0	0	0	67.68	0	0	12.2
2015	7	31	12	43	16	33		0	0	0	0	0	0	67.87	0	0	12.4
2015	7	31	12	53	16	32		0	0	0	0	0	0	67.8	0	0	12.2
2015	7	31	13	3	16	32		0	0	0	0	0	0	67.87	0	0	12.4
2015	7	31	13	13	16	32		0	0	0	0	0	0	67.82	0	0	12.2
2015	7	31	13	23	16	33		0	0	0	0	0	0	67.84	0	0	12.2
2015	7	31	13	33	16	33		0	0	0	0	0	0	67.86	0	0	12.2
2015	7	31	13	43	16	32		0	0	0	0	0	0	68.09	0	0	12.6
2015	7	31	13	53	16	32		0	0	0	0	0	0	68.14	0	0	12.6
2015	7	31	14	3	16	32		0	0	0	0	0	0	68.05	0	0	12.4
2015	7	31	14	13	16	33		0	0	0	0	0	0	68.14	0	0	12.4
2015	7	31	14	23	16	33		0	0	0	0	0	0	68.13	0	0	12.2
2015	7	31	14	33	16	32		0	0	0	0	0	0	68.27	0	0	12.4
2015	7	31	14	43	16	33		0	0	0	0	0	0	68.22	0	0	12.2
2015	7	31	14	53	16	33		0	0	0	0	0	0	68.4	0	0	12.6
2015	7	31	15	3	16	32		0	0	0	0	0	0	68.49	0	0	12.6
2015	7	31	15	13	16	32		0	0	0	0	0	0	68.5	0	0	12.6
2015	7	31	15	23	16	32		0	0	0	0	0	0	68.54	0	0	12.6
2015	7	31	15	33	16	32		0	0	0	0	0	0	68.54	0	0	12.4
2015	7	31	15	43	16	32		0	0	0	0	0	0	68.56	0	0	12.4
2015	7	31	15	53	16	32		0	0	0	0	0	0	68.58	0	0	12.4
2015	7	31	16	3	16	32		0	0	0	0	0	0	68.59	0	0	12.4
2015	7	31	16	13	16	32		0	0	0	0	0	0	68.61	0	0	12.4
2015	7	31	16	23	16	33		0	0	0	0	0	0	68.63	0	0	12.4
2015	7	31	16	33	16	32		0	0	0	0	0	0	68.65	0	0	12.4
2015	7	31	16	43	16	31		0	0	0	0	0	0	68.67	0	0	12.4

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	Noise3	IceDetection	Heading	Pitch	Roll	StdDevHeading	StdDevPitch	StdDevRoll	Temperature	Pressure	StdDevPressure	Voltage
2015	7	31	16	53	16	32		0	0	0	0	0	0	68.67	0	0	12.4
2015	7	31	17	3	16	32		0	0	0	0	0	0	68.67	0	0	12.2
2015	7	31	17	13	16	32		0	0	0	0	0	0	68.65	0	0	12.2
2015	7	31	17	23	16	33		0	0	0	0	0	0	68.68	0	0	12.2
2015	7	31	17	33	16	33		0	0	0	0	0	0	68.7	0	0	12.2
2015	7	31	17	43	16	32		0	0	0	0	0	0	68.74	0	0	12.2
2015	7	31	17	53	16	32		0	0	0	0	0	0	68.74	0	0	12.2
2015	7	31	18	3	16	32		0	0	0	0	0	0	68.72	0	0	12.2
2015	7	31	18	13	16	33		0	0	0	0	0	0	68.72	0	0	12
2015	7	31	18	23	16	32		0	0	0	0	0	0	68.74	0	0	12
2015	7	31	18	33	16	32		0	0	0	0	0	0	68.74	0	0	12
2015	7	31	18	43	16	32		0	0	0	0	0	0	68.76	0	0	12
2015	7	31	18	53	16	32		0	0	0	0	0	0	68.76	0	0	12
2015	7	31	19	3	16	32		0	0	0	0	0	0	68.76	0	0	12
2015	7	31	19	13	16	33		0	0	0	0	0	0	68.77	0	0	12
2015	7	31	19	23	16	32		0	0	0	0	0	0	68.79	0	0	12
2015	7	31	19	33	16	32		0	0	0	0	0	0	68.79	0	0	12
2015	7	31	19	43	16	32		0	0	0	0	0	0	68.79	0	0	12
2015	7	31	19	53	16	33		0	0	0	0	0	0	68.79	0	0	12
2015	7	31	20	3	16	33		0	0	0	0	0	0	68.79	0	0	12
2015	7	31	20	13	16	32		0	0	0	0	0	0	68.79	0	0	12
2015	7	31	20	23	16	31		0	0	0	0	0	0	68.79	0	0	12
2015	7	31	20	33	16	32		0	0	0	0	0	0	68.79	0	0	12
2015	7	31	20	43	16	33		0	0	0	0	0	0	68.79	0	0	12
2015	7	31	20	53	16	32		0	0	0	0	0	0	68.77	0	0	12
2015	7	31	21	3	16	32		0	0	0	0	0	0	68.77	0	0	12
2015	7	31	21	13	16	33		0	0	0	0	0	0	68.76	0	0	12
2015	7	31	21	23	16	32		0	0	0	0	0	0	68.76	0	0	12
2015	7	31	21	33	16	32		0	0	0	0	0	0	68.74	0	0	11.8
2015	7	31	21	43	16	33		0	0	0	0	0	0	68.72	0	0	11.8
2015	7	31	21	53	16	32		0	0	0	0	0	0	68.7	0	0	11.8
2015	7	31	22	3	16	33		0	0	0	0	0	0	68.68	0	0	11.8
2015	7	31	22	13	16	32		0	0	0	0	0	0	68.67	0	0	11.8
2015	7	31	22	23	16	32		0	0	0	0	0	0	68.65	0	0	11.8
2015	7	31	22	33	16	33		0	0	0	0	0	0	68.63	0	0	11.8
2015	7	31	22	43	16	32		0	0	0	0	0	0	68.61	0	0	11.8
2015	7	31	22	53	16	33		0	0	0	0	0	0	68.59	0	0	11.8
2015	7	31	23	3	16	33		0	0	0	0	0	0	68.56	0	0	11.8
2015	7	31	23	13	16	32		0	0	0	0	0	0	68.54	0	0	11.8
2015	7	31	23	23	16	31		0	0	0	0	0	0	68.5	0	0	11.8
2015	7	31	23	33	16	32		0	0	0	0	0	0	68.49	0	0	11.8
2015	7	31	23	43	16	33		0	0	0	0	0	0	68.45	0	0	11.8
2015	7	31	23	53	16	32		0	0	0	0	0	0	68.43	0	0	11.8

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	1	0	3	6	0.3	3.6	0.73	95.2	81.6535	56.2512
2015	7	1	0	13	6	0.3	3.6	0.75	95	81.5879	58.2385
2015	7	1	0	23	6	0.3	3.6	0.75	94.3	81.5879	57.7299
2015	7	1	0	33	6	0.3	3.6	0.76	96.2	81.5879	58.2385
2015	7	1	0	43	6	0.3	3.6	0.73	97.7	81.5223	56.1568
2015	7	1	0	53	6	0.3	3.6	0.75	94.7	81.5223	58.1896
2015	7	1	1	3	6	0.3	3.6	0.71	97.4	81.3911	54.794
2015	7	1	1	13	6	0.3	3.6	0.75	97.6	81.3255	57.2825
2015	7	1	1	23	6	0.3	3.6	0.78	97	81.1942	59.4632
2015	7	1	1	33	6	0.3	3.6	0.72	97.3	81.063	55.3211
2015	7	1	1	43	6	0.3	3.6	0.74	99.1	80.9318	56.4884
2015	7	1	1	53	6	0.3	3.6	0.7	98.4	80.8661	52.9131
2015	7	1	2	3	6	0.3	3.6	0.71	97.5	80.8661	53.9209
2015	7	1	2	13	6	0.3	3.6	0.72	98.1	80.8005	54.6305
2015	7	1	2	23	6	0.3	3.6	0.71	97.8	80.7349	53.578
2015	7	1	2	33	6	0.3	3.6	0.75	97.1	80.7349	56.848
2015	7	1	2	43	6	0.3	3.6	0.76	96.4	80.6693	58.0564
2015	7	1	2	53	6	0.3	3.6	0.72	94.9	80.6037	55.2448
2015	7	1	3	3	6	0.3	3.6	0.72	95.5	80.5381	54.4451
2015	7	1	3	13	6	0.3	3.6	0.7	97.6	80.4724	52.8947
2015	7	1	3	23	6	0.3	3.6	0.75	97.2	80.21	56.9615
2015	7	1	3	33	6	0.3	3.6	0.72	98.1	80.1444	54.4166
2015	7	1	3	43	6	0.3	3.6	0.73	98	80.0787	55.1183
2015	7	1	3	53	6	0.3	3.6	0.72	98.2	80.0131	53.8252
2015	7	1	4	3	6	0.3	3.6	0.71	95.8	79.9475	53.5301
2015	7	1	4	13	6	0.3	3.6	0.68	97.2	79.9475	51.2893
2015	7	1	4	23	6	0.3	3.6	0.71	98	79.8819	53.2354
2015	7	1	4	33	6	0.3	3.6	0.72	99.2	79.8163	53.6868
2015	7	1	4	43	6	0.3	3.6	0.72	96.6	79.7507	53.889
2015	7	1	4	53	6	0.3	3.6	0.72	96.8	79.6851	53.8427
2015	7	1	5	3	6	0.3	3.6	0.7	95.1	79.4226	52.1737
2015	7	1	5	13	6	0.3	3.6	0.73	94.4	79.357	55.0933
2015	7	1	5	23	6	0.3	3.6	0.73	97	79.2913	54.3052
2015	7	1	5	33	6	0.3	3.6	0.71	95.8	79.2257	53.0251
2015	7	1	5	43	6	0.3	3.6	0.69	95.5	79.1601	51.2543
2015	7	1	5	53	6	0.3	3.6	0.65	98.7	79.0945	48.2555
2015	7	1	6	3	6	0.3	3.6	0.62	96.1	78.9633	45.9598
2015	7	1	6	13	6	0.3	3.6	0.66	94.3	78.9633	49.4007
2015	7	1	6	23	6	0.3	3.6	0.64	95.9	78.9633	47.926
2015	7	1	6	33	6	0.3	3.6	0.65	94	78.832	48.5788
2015	7	1	6	43	6	0.3	3.6	0.65	96.7	78.7008	48.2494
2015	7	1	6	53	6	0.3	3.6	0.67	96.4	78.6352	49.9203
2015	7	1	7	3	6	0.3	3.6	0.65	96.9	78.5696	48.4098
2015	7	1	7	13	6	0.3	3.6	0.68	95.8	78.5039	50.566
2015	7	1	7	23	6	0.3	3.6	0.66	95.4	78.4383	48.8134
2015	7	1	7	33	6	0.3	3.6	0.68	97.5	78.3727	49.9899
2015	7	1	7	43	6	0.3	3.6	0.65	97.2	78.3071	47.9971

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	1	7	53	6	0.3	3.6	0.71	97.5	78.2415	52.0933
2015	7	1	8	3	6	0.3	3.6	0.64	97.1	78.1758	46.9401
2015	7	1	8	13	6	0.3	3.6	0.61	98	78.1758	44.7512
2015	7	1	8	23	6	0.3	3.6	0.65	97.6	78.0446	47.3433
2015	7	1	8	33	6	0.3	3.6	0.64	95.3	77.979	47.3017
2015	7	1	8	43	6	0.3	3.6	0.64	96.2	77.8478	46.7341
2015	7	1	8	53	6	0.3	3.6	0.67	96.4	77.7822	49.3542
2015	7	1	9	3	6	0.3	3.6	0.66	98.9	77.7165	48.1021
2015	7	1	9	13	6	0.3	3.6	0.66	98	77.6509	48.3011
2015	7	1	9	23	6	0.3	3.6	0.65	97.6	77.6509	47.0936
2015	7	1	9	33	6	0.3	3.6	0.67	95.1	77.5853	48.741
2015	7	1	9	43	6	0.3	3.6	0.69	96.3	77.5197	50.3855
2015	7	1	9	53	6	0.3	3.6	0.65	99	77.5197	47.0104
2015	7	1	10	3	6	0.3	3.6	0.67	97.7	77.4541	48.4139
2015	7	1	10	13	6	0.3	3.6	0.68	95	77.4541	49.8591
2015	7	1	10	23	6	0.3	3.6	0.67	95.1	77.3885	48.6117
2015	7	1	10	33	6	0.3	3.6	0.68	95.5	77.3228	49.5303
2015	7	1	10	43	6	0.3	3.6	0.66	97.8	77.2572	47.5646
2015	7	1	10	53	6	0.3	3.6	0.7	94.9	77.1916	50.8825
2015	7	1	11	3	6	0.3	3.6	0.68	97.2	76.9948	49.0712
2015	7	1	11	13	6	0.3	3.6	0.68	98.6	76.9948	49.0711
2015	7	1	11	23	6	0.3	3.6	0.7	98.4	76.9291	50.4623
2015	7	1	11	33	6	0.3	3.6	0.67	97.9	76.8635	48.2668
2015	7	1	11	43	6	0.3	3.6	0.69	95.4	76.8635	50.1784
2015	7	1	11	53	6	0.3	3.6	0.67	96.7	76.7979	48.4624
2015	7	1	12	3	6	0.3	3.6	0.65	95.5	76.7979	46.7913
2015	7	1	12	13	6	0.3	3.6	0.67	96.2	76.7979	48.4624
2015	7	1	12	23	6	0.3	3.6	0.67	96.7	76.7323	48.419
2015	7	1	12	33	6	0.3	3.6	0.65	98.5	76.7323	46.5108
2015	7	1	12	43	6	0.3	3.6	0.67	99.3	76.7323	47.9419
2015	7	1	12	53	6	0.3	3.6	0.66	96	76.6667	47.6608
2015	7	1	13	3	6	0.3	3.6	0.65	98.1	76.6667	46.9459
2015	7	1	13	13	6	0.3	3.6	0.66	97.5	76.6011	47.1419
2015	7	1	13	23	6	0.3	3.6	0.66	97.2	76.6011	47.38
2015	7	1	13	33	6	0.3	3.6	0.66	96	76.5354	47.8132
2015	7	1	13	43	6	0.3	3.3	0.72	98.4	76.4698	51.5729
2015	7	1	13	53	6	0.3	3.3	0.71	97.7	76.3386	51.0058
2015	7	1	14	3	6	0.3	3.3	0.68	99.4	76.273	48.5897
2015	7	1	14	13	6	0.3	3.3	0.64	97.7	76.2074	45.4674
2015	7	1	14	23	6	0.3	3.3	0.67	97.3	76.2074	47.8355
2015	7	1	14	33	6	0.3	3.3	0.68	98	76.1417	48.7389
2015	7	1	14	43	6	0.3	3.3	0.63	99.3	76.1417	44.7167
2015	7	1	14	53	6	0.3	3.3	0.66	96.3	76.1417	47.3192
2015	7	1	15	3	6	0.3	3.3	0.66	98.3	76.0761	47.2766
2015	7	1	15	13	6	0.3	3.3	0.63	97.5	76.0761	45.1491
2015	7	1	15	23	6	0.3	3.3	0.65	97.6	76.0761	46.0946
2015	7	1	15	33	6	0.3	3.3	0.66	96.5	76.0105	47.4701

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	1	15	43	6	0.3	3.3	0.63	98.6	76.0761	45.1491
2015	7	1	15	53	6	0.3	3.3	0.61	99.6	76.0105	43.4552
2015	7	1	16	3	6	0.3	3.3	0.62	94.9	76.0105	44.1637
2015	7	1	16	13	6	0.3	3.3	0.62	96.3	75.9449	44.5957
2015	7	1	16	23	6	0.3	3.3	0.64	100.4	76.0105	45.1083
2015	7	1	16	33	6	0.3	3.3	0.63	96	75.9449	45.0676
2015	7	1	16	43	6	0.3	3.3	0.62	100.6	75.8793	44.0838
2015	7	1	16	53	6	0.3	3.3	0.67	101	75.8793	47.3842
2015	7	1	17	3	6	0.3	3.3	0.61	96.2	75.8137	43.3374
2015	7	1	17	13	6	0.3	3.3	0.64	97	75.8137	45.9282
2015	7	1	17	23	6	0.3	3.3	0.65	100.1	75.8137	46.1637
2015	7	1	17	33	6	0.3	3.3	0.69	95.2	75.8137	49.4611
2015	7	1	17	43	6	0.3	3.3	0.67	97.3	75.748	48.0044
2015	7	1	17	53	6	0.3	3.3	0.65	95.5	75.748	46.3572
2015	7	1	18	3	6	0.3	3.3	0.69	97.9	75.6824	48.9013
2015	7	1	18	13	6	0.3	3.3	0.68	98.9	75.6168	48.1523
2015	7	1	18	23	6	0.3	3.3	0.67	98.7	75.6168	47.6825
2015	7	1	18	33	6	0.3	3.3	0.7	95.1	75.5512	49.986
2015	7	1	18	43	6	0.3	3.3	0.66	96.3	75.5512	46.9352
2015	7	1	18	53	6	0.3	3.3	0.67	97.9	75.5512	47.4045
2015	7	1	19	3	6	0.3	3.3	0.66	96	75.4856	46.658
2015	7	1	19	13	6	0.3	3.3	0.68	97.2	75.4856	48.5337
2015	7	1	19	23	6	0.3	3.3	0.69	97.6	75.4856	49.0027
2015	7	1	19	33	6	0.3	3.3	0.69	94.9	75.4856	49.4716
2015	7	1	19	43	6	0.3	3.3	0.67	97.6	75.4856	47.5959
2015	7	1	19	53	6	0.3	3.3	0.74	97.2	75.4856	52.2851
2015	7	1	20	3	6	0.3	3.3	0.7	96.7	75.4856	49.9405
2015	7	1	20	13	6	0.3	3.3	0.66	96	75.4856	46.658
2015	7	1	20	23	6	0.3	3.3	0.68	94.7	75.4856	48.5338
2015	7	1	20	33	6	0.3	3.3	0.7	96.4	75.4856	49.9405
2015	7	1	20	43	6	0.3	3.3	0.66	96.5	75.4856	47.127
2015	7	1	20	53	6	0.3	3.3	0.69	96.8	75.4856	49.2371
2015	7	1	21	3	6	0.3	3.3	0.71	96.6	75.4856	50.6439
2015	7	1	21	13	6	0.3	3.3	0.66	93.4	75.4856	46.8925
2015	7	1	21	23	6	0.3	3.3	0.67	96.8	75.4856	47.3615
2015	7	1	21	33	6	0.3	3.3	0.69	97.7	75.4856	48.5338
2015	7	1	21	43	6	0.3	3.3	0.63	95.4	75.4856	45.0168
2015	7	1	21	53	6	0.3	3.3	0.65	94	75.4856	46.4236
2015	7	1	22	3	6	0.3	3.3	0.67	96.8	75.4856	47.3615
2015	7	1	22	13	6	0.3	3.3	0.73	95.9	75.4856	52.0507
2015	7	1	22	23	6	0.3	3.3	0.68	98.4	75.4856	47.8304
2015	7	1	22	33	6	0.3	3.3	0.67	94.5	75.5512	47.8739
2015	7	1	22	43	6	0.3	3.3	0.66	96.5	75.5512	47.1699
2015	7	1	22	53	6	0.3	3.3	0.71	95.8	75.5512	50.4554
2015	7	1	23	3	6	0.3	3.3	0.69	97.7	75.6168	48.6221
2015	7	1	23	13	6	0.3	3.3	0.69	98.5	75.6168	48.857
2015	7	1	23	23	6	0.3	3.3	0.66	100.8	75.6824	46.7855

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	1	23	33	6	0.3	3.3	0.69	96.8	75.6824	49.1365
2015	7	1	23	43	6	0.3	3.3	0.71	98	75.748	50.1224
2015	7	1	23	53	6	0.3	3.3	0.68	92.8	75.748	48.7105
2015	7	2	0	3	6	0.3	3.3	0.7	97	75.8137	49.6967
2015	7	2	0	13	6	0.3	3.3	0.7	95.4	75.8137	49.6967
2015	7	2	0	23	6	0.3	3.3	0.71	95.6	75.8137	50.4033
2015	7	2	0	33	6	0.3	3.3	0.68	96.7	75.8137	48.2836
2015	7	2	0	43	6	0.3	3.3	0.7	95.7	75.8137	49.6968
2015	7	2	0	53	6	0.3	3.3	0.68	97.2	75.8793	48.3273
2015	7	2	1	3	6	0.3	3.3	0.7	96.2	75.8793	49.7418
2015	7	2	1	13	6	0.3	3.3	0.66	95.7	75.8793	47.3843
2015	7	2	1	23	6	0.3	3.3	0.63	97.8	75.8793	44.7912
2015	7	2	1	33	6	0.3	3.3	0.69	96	75.8793	49.506
2015	7	2	1	43	6	0.3	3.3	0.69	94.9	75.8793	49.2703
2015	7	2	1	53	6	0.3	3.3	0.71	97.8	75.9449	50.2587
2015	7	2	2	3	6	0.3	3.3	0.66	95.7	75.9449	46.9553
2015	7	2	2	13	6	0.3	3.3	0.65	96.7	75.9449	46.2475
2015	7	2	2	23	6	0.3	3.3	0.67	95.9	75.9449	47.6632
2015	7	2	2	33	6	0.3	3.3	0.68	93.6	75.9449	48.607
2015	7	2	2	43	6	0.3	3.3	0.67	95.9	75.9449	47.8992
2015	7	2	2	53	6	0.3	3.3	0.69	94.6	75.9449	49.5509
2015	7	2	3	3	6	0.3	3.3	0.69	93.3	75.9449	49.7868
2015	7	2	3	13	6	0.3	3.3	0.7	94.8	76.0105	50.5404
2015	7	2	3	23	6	0.3	3.3	0.68	97.2	76.0105	48.651
2015	7	2	3	33	6	0.3	3.3	0.73	97.7	76.0105	52.1936
2015	7	2	3	43	6	0.3	3.3	0.71	98	76.0105	50.5404
2015	7	2	3	53	6	0.3	3.3	0.68	96.1	76.0105	48.4148
2015	7	2	4	3	6	0.3	3.3	0.67	95.4	76.0105	47.7063
2015	7	2	4	13	6	0.3	3.3	0.66	95.7	76.0761	47.513
2015	7	2	4	23	6	0.3	3.3	0.68	94.1	76.0761	48.9314
2015	7	2	4	33	6	0.3	3.3	0.67	91.4	76.0761	48.4586
2015	7	2	4	43	6	0.3	3.3	0.69	93.8	76.0761	49.8769
2015	7	2	4	53	6	0.3	3.3	0.67	94.7	76.0761	48.4586
2015	7	2	5	3	6	0.3	3.3	0.69	95.2	76.0761	49.6405
2015	7	2	5	13	6	0.3	3.3	0.71	96.4	76.0761	50.8224
2015	7	2	5	23	6	0.3	3.3	0.69	94.6	76.0761	49.6405
2015	7	2	5	33	6	0.3	3.3	0.71	93.2	76.0761	50.8225
2015	7	2	5	43	6	0.3	3.3	0.71	99.6	76.0761	50.3497
2015	7	2	5	53	6	0.3	3.3	0.67	95.6	76.0761	47.9859
2015	7	2	6	3	6	0.3	3.3	0.68	97.2	76.0761	48.9314
2015	7	2	6	13	6	0.3	3.3	0.67	99	76.1417	47.556
2015	7	2	6	23	6	0.3	3.3	0.66	97.7	76.1417	47.3194
2015	7	2	6	33	6	0.3	3.3	0.68	95.5	76.1417	48.739
2015	7	2	6	43	6	0.3	3.3	0.71	98.2	76.1417	50.8683
2015	7	2	6	53	6	0.3	3.3	0.71	96.1	76.1417	50.6317
2015	7	2	7	3	6	0.3	3.3	0.68	98.9	76.1417	48.5024
2015	7	2	7	13	6	0.3	3.3	0.72	97.1	76.1417	51.3415

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	2	7	23	6	0.3	3.3	0.69	99	76.1417	49.4488
2015	7	2	7	33	6	0.3	3.3	0.68	98.4	76.1417	48.2658
2015	7	2	7	43	6	0.3	3.3	0.7	96.2	76.1417	50.1585
2015	7	2	7	53	6	0.3	3.3	0.69	96	76.1417	49.2122
2015	7	2	8	3	6	0.3	3.3	0.7	95.7	76.1417	49.9219
2015	7	2	8	13	6	0.3	3.3	0.67	97.1	76.1417	47.7926
2015	7	2	8	23	6	0.3	3.3	0.69	96.8	76.1417	49.6853
2015	7	2	8	33	6	0.3	3.3	0.71	98	76.1417	50.6317
2015	7	2	8	43	6	0.3	3.3	0.69	97.4	76.1417	49.2121
2015	7	2	8	53	6	0.3	3.3	0.72	95.8	76.1417	51.3415
2015	7	2	9	3	6	0.3	3.3	0.7	95.1	76.1417	49.9219
2015	7	2	9	13	6	0.3	3.3	0.68	100	76.1417	48.5023
2015	7	2	9	23	6	0.3	3.3	0.67	98.2	76.1417	47.556
2015	7	2	9	33	6	0.3	3.3	0.7	96.7	76.1417	50.1585
2015	7	2	9	43	6	0.3	3.3	0.69	101.2	76.0761	48.9313
2015	7	2	9	53	6	0.3	3.3	0.65	97.5	76.0761	46.5675
2015	7	2	10	3	6	0.3	3.3	0.62	97.6	76.0761	44.2037
2015	7	2	10	13	6	0.3	3.3	0.64	97.7	76.0761	45.622
2015	7	2	10	23	6	0.3	3.3	0.67	95.9	76.0761	48.2222
2015	7	2	10	33	6	0.3	3.3	0.63	97.8	76.0761	45.1492
2015	7	2	10	43	6	0.3	3.3	0.67	95.9	76.0761	47.7494
2015	7	2	10	53	6	0.3	3.3	0.68	96.4	76.0761	48.6949
2015	7	2	11	3	6	0.3	3.3	0.69	97.9	76.0761	49.1677
2015	7	2	11	13	6	0.3	3.3	0.67	95.4	76.0761	47.7494
2015	7	2	11	23	6	0.3	3.3	0.7	95.9	76.0761	50.1132
2015	7	2	11	33	6	0.3	3.3	0.68	94.4	76.0761	48.6949
2015	7	2	11	43	6	0.3	3.3	0.63	97.8	76.0761	45.1491
2015	7	2	11	53	6	0.3	3.3	0.63	97.8	76.0761	44.9127
2015	7	2	12	3	6	0.3	3.3	0.67	100.1	76.0761	47.7493
2015	7	2	12	13	6	0.3	3.3	0.68	97.2	76.0761	48.9311
2015	7	2	12	23	6	0.3	3.3	0.63	93.6	76.0761	45.6218
2015	7	2	12	33	6	0.3	3.3	0.68	97.5	76.0761	48.4584
2015	7	2	12	43	6	0.3	3.3	0.66	97.2	76.0761	47.0401
2015	7	2	12	53	6	0.3	3.3	0.7	96.2	76.0761	50.3494
2015	7	2	13	3	6	0.3	3.3	0.67	97.9	76.0105	47.4699
2015	7	2	13	13	6	0.3	3.3	0.65	96.9	76.0761	46.8036
2015	7	2	13	23	6	0.3	3.3	0.67	95.1	76.0105	47.9423
2015	7	2	13	33	6	0.3	3.3	0.69	96.8	76.0105	49.3593
2015	7	2	13	43	6	0.3	3.3	0.66	96	76.0105	47.2338
2015	7	2	13	53	6	0.3	3.3	0.65	94.7	76.0105	46.289
2015	7	2	14	3	6	0.3	3.3	0.66	96.6	76.0105	46.9975
2015	7	2	14	13	6	0.3	3.3	0.69	96.9	76.0105	49.1231
2015	7	2	14	23	6	0.3	3.3	0.67	97.3	75.9449	47.663
2015	7	2	14	33	6	0.3	3.3	0.69	92.2	76.0105	49.3591
2015	7	2	14	43	6	0.3	3.3	0.64	91.8	76.0105	46.2889
2015	7	2	14	53	6	0.3	3.3	0.67	93.4	75.9449	48.1348
2015	7	2	15	3	6	0.3	3.3	0.66	97.1	75.9449	47.4269

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	2	15	13	6	0.3	3.3	0.7	93.5	75.9449	50.2583
2015	7	2	15	23	6	0.3	3.3	0.66	94	75.9449	47.6628
2015	7	2	15	33	6	0.3	3.3	0.64	95	75.9449	46.0111
2015	7	2	15	43	6	0.3	3.3	0.66	99.4	75.8793	46.9125
2015	7	2	15	53	6	0.3	3.3	0.65	96.1	75.8793	46.2052
2015	7	2	16	3	6	0.3	3.3	0.67	97	75.8793	48.0912
2015	7	2	16	13	6	0.3	3.3	0.66	96.8	75.8793	47.1482
2015	7	2	16	23	6	0.3	3.3	0.67	97.9	75.8137	47.341
2015	7	2	16	33	6	0.3	3.3	0.64	96.1	75.748	45.8863
2015	7	2	16	43	6	0.3	3.3	0.65	97.6	75.6824	45.8447
2015	7	2	16	53	6	0.3	3.3	0.67	97.9	75.6824	47.7255
2015	7	2	17	3	6	0.3	3.3	0.64	99.2	75.6168	45.0985
2015	7	2	17	13	6	0.3	3.3	0.65	98.1	75.6168	46.038
2015	7	2	17	23	6	0.3	3.3	0.67	98.7	75.6168	47.4473
2015	7	2	17	33	6	0.3	3.3	0.62	96.7	75.6168	44.1589
2015	7	2	17	43	6	0.3	3.3	0.65	99.4	75.6168	45.5682
2015	7	2	17	53	6	0.3	3.3	0.63	93	75.6168	45.3333
2015	7	2	18	3	6	0.3	3.3	0.66	98.3	75.5512	46.9349
2015	7	2	18	13	6	0.3	3.3	0.69	98.2	75.6168	48.8567
2015	7	2	18	23	6	0.3	3.3	0.64	99.2	75.6168	45.0984
2015	7	2	18	33	6	0.3	3.3	0.66	97.4	75.6168	46.7426
2015	7	2	18	43	6	0.3	3.3	0.7	95.1	75.6168	49.7962
2015	7	2	18	53	6	0.3	3.3	0.69	97.4	75.6168	48.8566
2015	7	2	19	3	6	0.3	3.3	0.68	97.4	75.6824	48.6659
2015	7	2	19	13	6	0.3	3.3	0.69	96.3	75.6824	49.1361
2015	7	2	19	23	6	0.3	3.3	0.66	94.6	75.8137	47.1055
2015	7	2	19	33	6	0.3	3.3	0.65	95.8	75.8137	46.1634
2015	7	2	19	43	6	0.3	3.3	0.67	98.4	75.8793	47.8554
2015	7	2	19	53	6	0.3	3.3	0.71	96.4	75.9449	50.4942
2015	7	2	20	3	6	0.3	3.3	0.69	97.6	75.9449	49.3144
2015	7	2	20	13	6	0.3	3.3	0.7	97.3	75.9449	50.0223
2015	7	2	20	23	6	0.3	3.3	0.73	98.6	76.0105	51.7207
2015	7	2	20	33	6	0.3	3.3	0.66	95.2	76.0105	46.9973
2015	7	2	20	43	6	0.3	3.3	0.68	98.4	76.0761	48.2217
2015	7	2	20	53	6	0.3	3.3	0.7	96.2	76.0761	50.3491
2015	7	2	21	3	6	0.3	3.3	0.65	97.5	76.0761	46.567
2015	7	2	21	13	6	0.3	3.3	0.7	97.5	76.1417	50.3946
2015	7	2	21	23	6	0.3	3.3	0.71	94.5	76.1417	51.341
2015	7	2	21	33	6	0.3	3.3	0.7	95.7	76.1417	50.158
2015	7	2	21	43	6	0.3	3.3	0.71	95.9	76.2074	50.6768
2015	7	2	21	53	6	0.3	3.3	0.7	94.3	76.2074	50.2032
2015	7	2	22	3	6	0.3	3.3	0.67	96.8	76.273	47.8782
2015	7	2	22	13	6	0.3	3.3	0.67	94.7	76.273	48.5893
2015	7	2	22	23	6	0.3	3.3	0.71	96.7	76.3386	50.7682
2015	7	2	22	33	6	0.3	3.3	0.69	94.4	76.4698	49.9089
2015	7	2	22	43	6	0.3	3.6	0.7	97.5	76.6667	50.7582
2015	7	2	22	53	6	0.3	3.6	0.66	98.3	76.7323	47.7029

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	2	23	3	6	0.3	3.6	0.72	96	76.7979	52.0427
2015	7	2	23	13	6	0.3	3.6	0.68	95.2	76.7979	49.4167
2015	7	2	23	23	6	0.3	3.6	0.67	97	76.8635	48.7441
2015	7	2	23	33	6	0.3	3.6	0.74	95.6	76.8635	53.7619
2015	7	2	23	43	6	0.3	3.6	0.7	95.4	76.8635	50.4167
2015	7	2	23	53	6	0.3	3.6	0.73	94.9	76.9291	53.3316
2015	7	3	0	3	6	0.3	3.6	0.67	97.6	77.0604	48.3956
2015	7	3	0	13	6	0.3	3.6	0.71	97.5	77.0604	51.2705
2015	7	3	0	23	6	0.3	3.6	0.76	95.2	77.1916	55.202
2015	7	3	0	33	6	0.3	3.6	0.72	98.1	77.3885	52.4615
2015	7	3	0	43	6	0.3	3.6	0.71	99.3	77.4541	51.5446
2015	7	3	0	53	6	0.3	3.6	0.69	93.6	77.5197	50.3849
2015	7	3	1	3	6	0.3	3.6	0.73	95.4	77.5853	53.325
2015	7	3	1	13	6	0.3	3.6	0.7	95.6	77.6509	51.4401
2015	7	3	1	23	6	0.3	3.6	0.7	97.5	77.6509	51.4401
2015	7	3	1	33	6	0.3	3.6	0.68	93.9	77.7165	50.277
2015	7	3	1	43	6	0.3	3.6	0.74	96.4	77.7822	53.9503
2015	7	3	1	53	6	0.3	3.6	0.72	96	77.8478	52.7872
2015	7	3	2	3	6	0.3	3.6	0.68	98.3	77.9134	49.9255
2015	7	3	2	13	6	0.3	3.6	0.72	99.4	78.1758	52.7767
2015	7	3	2	23	6	0.3	3.6	0.68	97.7	78.2415	50.1453
2015	7	3	2	33	6	0.3	3.6	0.74	96.8	78.3071	54.8184
2015	7	3	2	43	6	0.3	3.6	0.69	96	78.3727	50.721
2015	7	3	2	53	6	0.3	3.6	0.72	95.8	78.4383	53.206
2015	7	3	3	3	6	0.3	3.6	0.75	95.2	78.4383	55.8907
2015	7	3	3	13	6	0.3	3.6	0.76	96.2	78.5039	55.9396
2015	7	3	3	23	6	0.3	3.6	0.73	96.2	78.5696	53.7881
2015	7	3	3	33	6	0.3	3.6	0.74	94.6	78.5696	55.2551
2015	7	3	3	43	6	0.3	3.6	0.69	96.5	78.6352	51.388
2015	7	3	3	53	6	0.3	3.6	0.71	96.7	78.8976	52.5496
2015	7	3	4	3	6	0.3	3.6	0.74	94.6	78.9633	55.053
2015	7	3	4	13	6	0.3	3.6	0.73	94.1	79.0945	54.6563
2015	7	3	4	23	6	0.3	3.6	0.74	97.7	79.1601	54.9501
2015	7	3	4	33	6	0.3	3.6	0.75	96.3	79.1601	56.1822
2015	7	3	4	43	6	0.3	3.6	0.72	95	79.2257	53.7646
2015	7	3	4	53	6	0.3	3.6	0.7	93.8	79.2257	52.2848
2015	7	3	5	3	6	0.3	3.6	0.71	94.2	79.2913	53.5643
2015	7	3	5	13	6	0.3	3.6	0.75	95.3	79.2913	56.2796
2015	7	3	5	23	6	0.3	3.6	0.69	94.6	79.357	51.8813
2015	7	3	5	33	6	0.3	3.6	0.74	98.7	79.4226	54.8934
2015	7	3	5	43	6	0.3	3.6	0.75	96.3	79.5538	55.9789
2015	7	3	5	53	6	0.3	3.6	0.77	96.2	79.7507	57.6138
2015	7	3	6	3	6	0.3	3.6	0.73	96.5	79.8163	54.6807
2015	7	3	6	13	6	0.3	3.6	0.76	96.7	79.8819	57.2154
2015	7	3	6	23	6	0.3	3.6	0.71	96.6	79.9475	53.5299
2015	7	3	6	33	6	0.3	3.6	0.71	95	79.9475	54.0278
2015	7	3	6	43	6	0.3	3.6	0.73	95.4	79.9475	55.5217

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	3	6	53	6	0.3	3.6	0.72	96.5	80.0131	54.3234
2015	7	3	7	3	6	0.3	3.6	0.75	96.3	80.0131	56.3169
2015	7	3	7	13	6	0.3	3.6	0.73	98.5	80.0787	55.1181
2015	7	3	7	23	6	0.3	3.6	0.74	96.7	80.0787	55.617
2015	7	3	7	33	6	0.3	3.6	0.77	96.3	80.1444	58.4104
2015	7	3	7	43	6	0.3	3.6	0.69	97.6	80.21	52.2146
2015	7	3	7	53	6	0.3	3.6	0.76	96.2	80.2756	57.5102
2015	7	3	8	3	6	0.3	3.6	0.74	95.9	80.4068	55.8551
2015	7	3	8	13	6	0.3	3.6	0.76	93	80.5381	58.2085
2015	7	3	8	23	6	0.3	3.6	0.72	95.8	80.5381	54.6959
2015	7	3	8	33	6	0.3	3.6	0.76	99.1	80.6037	57.7558
2015	7	3	8	43	6	0.3	3.6	0.74	95.3	80.6693	56.7996
2015	7	3	8	53	6	0.3	3.6	0.77	96.3	80.6693	58.8102
2015	7	3	9	3	6	0.3	3.6	0.73	95.5	80.7349	55.3387
2015	7	3	9	13	6	0.3	3.6	0.73	96.5	80.7349	55.3386
2015	7	3	9	23	6	0.3	3.6	0.72	93.4	80.7349	54.8356
2015	7	3	9	33	6	0.3	3.6	0.77	94.4	80.8005	58.6584
2015	7	3	9	43	6	0.3	3.6	0.75	94.5	80.8005	57.6514
2015	7	3	9	53	6	0.3	3.6	0.75	97.2	80.8005	57.3996
2015	7	3	10	3	6	0.3	3.6	0.74	95.1	80.8005	56.8961
2015	7	3	10	13	6	0.3	3.6	0.74	95.4	80.8661	56.4404
2015	7	3	10	23	6	0.3	3.6	0.78	96.6	80.8661	59.212
2015	7	3	10	33	6	0.3	3.6	0.74	95.6	80.8661	56.1884
2015	7	3	10	43	6	0.3	3.6	0.75	97.6	80.9318	56.9926
2015	7	3	10	53	6	0.3	3.6	0.8	94.5	80.9318	61.0275
2015	7	3	11	3	6	0.3	3.6	0.75	94.2	80.9318	57.7491
2015	7	3	11	13	6	0.3	3.6	0.72	95.5	80.9974	55.2741
2015	7	3	11	23	6	0.3	3.6	0.7	96.8	80.9974	53.2549
2015	7	3	11	33	6	0.3	3.6	0.73	97.4	80.9974	56.0312
2015	7	3	11	43	6	0.3	3.6	0.72	98.2	81.063	54.563
2015	7	3	11	53	6	0.3	3.6	0.71	97.7	81.063	54.0578
2015	7	3	12	3	6	0.3	3.6	0.7	96.8	81.1286	53.345
2015	7	3	12	13	6	0.3	3.6	0.68	97.8	81.1286	51.5752
2015	7	3	12	23	6	0.3	3.6	0.72	96.5	81.1286	55.1147
2015	7	3	12	33	6	0.3	3.6	0.72	97.8	81.1942	55.1613
2015	7	3	12	43	6	0.3	3.6	0.74	96.9	81.1942	56.6794
2015	7	3	12	53	6	0.3	3.6	0.71	94.3	81.1942	54.4021
2015	7	3	13	3	6	0.3	3.6	0.67	99.6	81.2598	50.6493
2015	7	3	13	13	6	0.3	3.6	0.73	97	81.3255	55.7613
2015	7	3	13	23	6	0.3	3.6	0.68	98.9	81.3255	51.7059
2015	7	3	13	33	6	0.3	3.6	0.68	97.4	81.2598	52.422
2015	7	3	13	43	6	0.3	3.6	0.74	96.1	81.3255	57.0285
2015	7	3	13	53	6	0.3	3.6	0.74	96.9	81.3911	56.8229
2015	7	3	14	3	6	0.3	3.6	0.78	96.6	81.3911	59.6133
2015	7	3	14	13	6	0.3	3.6	0.72	98.1	81.3911	55.0472
2015	7	3	14	23	6	0.3	3.6	0.74	96.4	81.3911	56.5692
2015	7	3	14	33	6	0.3	3.6	0.71	96.9	81.3911	54.5398

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	3	14	43	6	0.3	3.6	0.75	97.3	81.3911	57.3302
2015	7	3	14	53	6	0.3	3.6	0.72	93.6	81.3911	55.8081
2015	7	3	15	3	6	0.3	3.6	0.74	96.6	81.3911	56.8228
2015	7	3	15	13	6	0.3	3.6	0.74	96.1	81.4567	56.8707
2015	7	3	15	23	6	0.3	3.6	0.72	99.2	81.3911	54.7934
2015	7	3	15	33	6	0.3	3.6	0.72	98.6	81.4567	55.3473
2015	7	3	15	43	6	0.3	3.6	0.75	96.1	81.5223	57.4267
2015	7	3	15	53	6	0.3	3.6	0.69	97.1	81.4567	53.3162
2015	7	3	16	3	6	0.3	3.6	0.68	97.2	81.4567	52.0468
2015	7	3	16	13	6	0.3	3.6	0.72	96.3	81.4567	55.6012
2015	7	3	16	23	6	0.3	3.6	0.75	97	81.4567	57.8862
2015	7	3	16	33	6	0.3	3.6	0.72	99.2	81.4567	54.8395
2015	7	3	16	43	6	0.3	3.6	0.72	96.8	81.5223	55.1398
2015	7	3	16	53	6	0.3	3.6	0.74	96.6	81.5223	56.9185
2015	7	3	17	3	6	0.3	3.6	0.71	97.7	81.5223	54.3775
2015	7	3	17	13	6	0.3	3.6	0.74	98.1	81.5223	56.9185
2015	7	3	17	23	6	0.3	3.6	0.73	95.5	81.5223	55.9021
2015	7	3	17	33	6	0.3	3.6	0.76	95.2	81.5879	58.4923
2015	7	3	17	43	6	0.3	3.6	0.7	98.9	81.5879	53.406
2015	7	3	17	53	6	0.3	3.6	0.75	96.6	81.5879	57.475
2015	7	3	18	3	6	0.3	3.6	0.75	95.3	81.5879	57.9837
2015	7	3	18	13	6	0.3	3.6	0.75	96.6	81.5879	57.475
2015	7	3	18	23	6	0.3	3.6	0.73	98.3	81.6535	55.7416
2015	7	3	18	33	6	0.3	3.6	0.76	95.4	81.5879	58.7466
2015	7	3	18	43	6	0.3	3.6	0.76	93.5	81.5223	58.9514
2015	7	3	18	53	6	0.3	3.6	0.76	98.4	81.5223	58.1891
2015	7	3	19	3	6	0.3	3.6	0.77	93.9	81.6535	59.8141
2015	7	3	19	13	6	0.3	3.6	0.7	96.2	81.5223	54.1235
2015	7	3	19	23	6	0.3	3.6	0.81	92.3	81.5879	62.8157
2015	7	3	19	33	6	0.3	3.6	0.77	96.6	81.5879	59.001
2015	7	3	19	43	6	0.3	3.6	0.74	96.4	81.7192	56.8074
2015	7	3	19	53	6	0.3	3.6	0.76	95.7	81.7192	58.8454
2015	7	3	20	3	6	0.3	3.6	0.74	94.8	81.6535	57.5234
2015	7	3	20	13	6	0.3	3.6	0.72	96.8	81.6535	55.4872
2015	7	3	20	23	6	0.3	3.6	0.77	101	81.6535	58.796
2015	7	3	20	33	6	0.3	3.6	0.77	95.9	81.7848	59.6596
2015	7	3	20	43	6	0.3	3.6	0.74	96.3	81.7848	57.3651
2015	7	3	20	53	6	0.3	3.6	0.73	96.5	81.7848	56.3452
2015	7	3	21	3	6	0.3	3.6	0.76	97.5	81.7848	58.3849
2015	7	3	21	13	6	0.3	3.6	0.72	95.2	81.7848	56.0903
2015	7	3	21	23	6	0.3	3.6	0.76	99.7	81.7848	58.3849
2015	7	3	21	33	6	0.3	3.6	0.74	96.9	81.8504	57.158
2015	7	3	21	43	6	0.3	3.6	0.66	106.2	81.8504	49.2478
2015	7	3	21	53	6	0.3	3.6	0.71	103.5	81.8504	53.3305
2015	7	3	22	3	6	0.3	3.6	0.73	98.8	81.8504	55.8822
2015	7	3	22	13	6	0.3	3.6	0.75	103.1	81.8504	56.9029
2015	7	3	22	23	6	0.3	3.6	0.7	103.8	81.916	53.1198

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	3	22	33	6	0.3	3.6	0.69	104	81.9816	52.3975
2015	7	3	22	43	6	0.3	3.6	0.72	103.7	82.1129	54.5333
2015	7	3	22	53	6	0.3	3.6	0.67	104.9	82.1785	50.2228
2015	7	3	23	3	6	0.3	3.6	0.7	104.9	82.1785	52.7852
2015	7	3	23	13	6	0.3	3.6	0.69	104.4	82.1785	52.0165
2015	7	3	23	23	6	0.3	3.6	0.71	101.9	82.1785	54.5789
2015	7	3	23	33	6	0.3	3.6	0.66	105.3	82.2441	49.7518
2015	7	3	23	43	6	0.3	3.6	0.67	103.4	82.2441	50.7776
2015	7	3	23	53	6	0.3	3.6	0.68	106.6	82.2441	50.7776
2015	7	4	0	3	6	0.3	3.6	0.67	103.1	82.2441	50.7777
2015	7	4	0	13	6	0.3	3.6	0.68	100.3	82.2441	52.3164
2015	7	4	0	23	6	0.3	3.6	0.75	100.4	82.3097	57.4933
2015	7	4	0	33	6	0.3	3.6	0.73	99.8	82.3097	56.21
2015	7	4	0	43	6	0.3	3.6	0.68	98.8	82.3097	52.8733
2015	7	4	0	53	6	0.3	3.6	0.73	95.4	82.3097	56.98
2015	7	4	1	3	6	0.3	3.6	0.74	99.1	82.3097	57.4933
2015	7	4	1	13	6	0.3	3.6	0.77	98.3	82.3753	59.5962
2015	7	4	1	23	6	0.3	3.6	0.77	96.1	82.3753	60.11
2015	7	4	1	33	6	0.3	3.6	0.77	96.6	82.3753	59.5963
2015	7	4	1	43	6	0.3	3.6	0.76	100.2	82.3753	58.8256
2015	7	4	1	53	6	0.3	3.6	0.69	99	82.3753	53.688
2015	7	4	2	3	6	0.3	3.6	0.71	97.7	82.3753	55.2293
2015	7	4	2	13	6	0.3	3.6	0.73	101.9	82.3753	55.9999
2015	7	4	2	23	6	0.3	3.6	0.72	99.7	82.3753	55.7431
2015	7	4	2	33	6	0.3	3.6	0.75	96.6	82.3753	58.055
2015	7	4	2	43	6	0.3	3.6	0.75	97.8	82.3753	58.055
2015	7	4	2	53	6	0.3	3.6	0.7	99.4	82.4409	54.2469
2015	7	4	3	3	6	0.3	3.6	0.71	100.6	82.3753	54.9724
2015	7	4	3	13	6	0.3	3.6	0.78	101.9	82.4409	59.6459
2015	7	4	3	23	6	0.3	3.6	0.66	102.3	82.4409	50.9047
2015	7	4	3	33	6	0.3	3.6	0.76	96	82.3753	58.8257
2015	7	4	3	43	6	0.3	3.6	0.69	99.3	82.4409	53.2186
2015	7	4	3	53	6	0.3	3.6	0.69	101.3	82.4409	52.7044
2015	7	4	4	3	6	0.3	3.6	0.67	106.2	82.4409	50.3905
2015	7	4	4	13	6	0.3	3.6	0.63	105.2	82.4409	47.3054
2015	7	4	4	23	6	0.3	3.6	0.73	99.6	82.4409	56.0466
2015	7	4	4	33	6	0.3	3.6	0.7	101.7	82.4409	53.4757
2015	7	4	4	43	6	0.3	3.6	0.7	100.7	82.4409	54.247
2015	7	4	4	53	6	0.3	3.6	0.67	103.4	82.4409	50.9048
2015	7	4	5	3	6	0.3	3.6	0.72	103.5	82.4409	54.7612
2015	7	4	5	13	6	0.3	3.6	0.7	105.4	82.4409	53.2186
2015	7	4	5	23	6	0.3	3.6	0.69	105.6	82.4409	52.4474
2015	7	4	5	33	6	0.3	3.6	0.71	105.7	82.5066	53.2629
2015	7	4	5	43	6	0.3	3.6	0.67	104.8	82.5066	50.6898
2015	7	4	5	53	6	0.3	3.6	0.69	102.9	82.5066	53.0056
2015	7	4	6	3	6	0.3	3.6	0.7	104.9	82.5066	53.2629
2015	7	4	6	13	6	0.3	3.6	0.73	99.3	82.5066	56.6079

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	4	6	23	6	0.3	3.6	0.71	102	82.5066	54.2922
2015	7	4	6	33	6	0.3	3.6	0.7	104.2	82.5066	53.0057
2015	7	4	6	43	6	0.3	3.6	0.69	102	82.5066	53.263
2015	7	4	6	53	6	0.3	3.6	0.69	105.2	82.5066	51.9764
2015	7	4	7	3	6	0.3	3.6	0.73	101	82.5066	55.8361
2015	7	4	7	13	6	0.3	3.6	0.74	101.5	82.5722	56.9126
2015	7	4	7	23	6	0.3	3.6	0.71	102.8	82.5722	54.3374
2015	7	4	7	33	6	0.3	3.6	0.73	100.6	82.5722	56.6551
2015	7	4	7	43	6	0.3	3.6	0.65	104.6	82.5722	49.4444
2015	7	4	7	53	6	0.3	3.6	0.69	102.3	82.5722	53.0498
2015	7	4	8	3	6	0.3	3.6	0.75	98.1	82.5722	57.9427
2015	7	4	8	13	6	0.3	3.6	0.71	99.6	82.5722	54.8524
2015	7	4	8	23	6	0.3	3.6	0.68	101.5	82.5722	52.0197
2015	7	4	8	33	6	0.3	3.6	0.67	100.4	82.5722	52.0197
2015	7	4	8	43	6	0.3	3.6	0.66	103.1	82.5722	50.7321
2015	7	4	8	53	6	0.3	3.6	0.73	99.8	82.5722	56.3976
2015	7	4	9	3	6	0.3	3.6	0.72	99.4	82.5722	55.8825
2015	7	4	9	13	6	0.3	3.6	0.69	101	82.5722	53.0498
2015	7	4	9	23	6	0.3	3.6	0.72	100.7	82.5722	55.8825
2015	7	4	9	33	6	0.3	3.6	0.71	100.9	82.6378	54.898
2015	7	4	9	43	6	0.3	3.6	0.69	101	82.5722	53.0498
2015	7	4	9	53	6	0.3	3.6	0.72	98.9	82.5722	55.8825
2015	7	4	10	3	6	0.3	3.6	0.69	102.3	82.5722	53.0498
2015	7	4	10	13	6	0.3	3.6	0.69	102.1	82.5722	52.7922
2015	7	4	10	23	6	0.3	3.6	0.67	102.2	82.5722	51.2471
2015	7	4	10	33	6	0.3	3.6	0.69	101	82.5722	53.0497
2015	7	4	10	43	6	0.3	3.6	0.76	98.2	82.5722	58.9727
2015	7	4	10	53	6	0.3	3.6	0.69	96.8	82.5722	53.8222
2015	7	4	11	3	6	0.3	3.6	0.73	99.3	82.5722	56.6549
2015	7	4	11	13	6	0.3	3.6	0.69	101.3	82.5722	52.7921
2015	7	4	11	23	6	0.3	3.6	0.76	99	82.5722	58.7151
2015	7	4	11	33	6	0.3	3.6	0.75	97.8	82.5722	58.2001
2015	7	4	11	43	6	0.3	3.6	0.73	97.2	82.5722	56.9125
2015	7	4	11	53	6	0.3	3.6	0.79	95.3	82.5722	61.5479
2015	7	4	12	3	6	0.3	3.6	0.72	98.1	82.5066	55.836
2015	7	4	12	13	6	0.3	3.6	0.76	100.6	82.5722	58.9726
2015	7	4	12	23	6	0.3	3.6	0.71	98.8	82.5722	55.1097
2015	7	4	12	33	6	0.3	3.6	0.72	99.2	82.5722	55.6247
2015	7	4	12	43	6	0.3	3.6	0.77	97.3	82.5722	60.2602
2015	7	4	12	53	6	0.3	3.6	0.73	96.7	82.5722	56.9123
2015	7	4	13	3	6	0.3	3.6	0.73	94.9	82.5722	57.1699
2015	7	4	13	13	6	0.3	3.6	0.72	101.8	82.5722	55.6247
2015	7	4	13	23	6	0.3	3.6	0.73	99.8	82.5722	56.3972
2015	7	4	13	33	6	0.3	3.6	0.75	97.7	82.5722	58.7149
2015	7	4	13	43	6	0.3	3.6	0.72	97.3	82.5722	56.3972
2015	7	4	13	53	6	0.3	3.6	0.74	100	82.5722	57.1698
2015	7	4	14	3	6	0.3	3.6	0.75	96.5	82.5722	58.7149

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	4	14	13	6	0.3	3.6	0.71	98.5	82.5722	55.1096
2015	7	4	14	23	6	0.3	3.6	0.72	100.8	82.5722	55.3671
2015	7	4	14	33	6	0.3	3.6	0.72	104.5	82.5722	54.8521
2015	7	4	14	43	6	0.3	3.6	0.71	99.8	82.5722	55.1095
2015	7	4	14	53	6	0.3	3.6	0.73	99.3	82.5722	56.6546
2015	7	4	15	3	6	0.3	3.6	0.71	99.5	82.5722	55.1095
2015	7	4	15	13	6	0.3	3.6	0.69	100.2	82.5722	53.0494
2015	7	4	15	23	6	0.3	3.6	0.72	101.8	82.5722	55.6246
2015	7	4	15	33	6	0.3	3.6	0.72	102.4	82.5722	54.852
2015	7	4	15	43	6	0.3	3.6	0.73	98.8	82.5722	56.3971
2015	7	4	15	53	6	0.3	3.6	0.73	99	82.5722	56.6546
2015	7	4	16	3	6	0.3	3.6	0.7	99.5	82.5722	53.8219
2015	7	4	16	13	6	0.3	3.6	0.74	97.6	82.5722	57.9422
2015	7	4	16	23	6	0.3	3.6	0.74	97.9	82.5722	57.1697
2015	7	4	16	33	6	0.3	3.6	0.74	94.3	82.5722	57.9422
2015	7	4	16	43	6	0.3	3.6	0.73	98	82.5722	56.9122
2015	7	4	16	53	6	0.3	3.6	0.74	96.9	82.5722	57.6847
2015	7	4	17	3	6	0.3	3.6	0.75	98	82.5722	58.4573
2015	7	4	17	13	6	0.3	3.6	0.78	97.5	82.5722	60.775
2015	7	4	17	23	6	0.3	3.6	0.73	99	82.5722	56.9122
2015	7	4	17	33	6	0.3	3.6	0.73	100.1	82.5722	56.6547
2015	7	4	17	43	6	0.3	3.6	0.71	102.2	82.5722	54.852
2015	7	4	17	53	6	0.3	3.6	0.72	100.3	82.6378	55.413
2015	7	4	18	3	6	0.3	3.6	0.73	99	82.5722	56.9122
2015	7	4	18	13	6	0.3	3.6	0.75	98.1	82.6378	57.9904
2015	7	4	18	23	6	0.3	3.6	0.74	96.7	82.6378	57.4749
2015	7	4	18	33	6	0.3	3.6	0.71	98	82.7034	54.9431
2015	7	4	18	43	6	0.3	3.6	0.79	97.6	82.7034	61.9077
2015	7	4	18	53	6	0.3	3.6	0.74	97.9	82.6378	57.475
2015	7	4	19	3	6	0.3	3.6	0.71	94.5	82.7034	55.459
2015	7	4	19	13	6	0.3	3.6	0.75	94.3	82.769	58.603
2015	7	4	19	23	6	0.3	3.6	0.74	96.9	82.769	57.8285
2015	7	4	19	33	6	0.3	3.6	0.76	96.5	82.8347	59.1683
2015	7	4	19	43	6	0.3	3.6	0.78	96.6	82.8347	60.7185
2015	7	4	19	53	6	0.3	3.6	0.73	95.4	82.9003	57.4071
2015	7	4	20	3	6	0.3	3.6	0.72	99.4	82.9659	56.1606
2015	7	4	20	13	6	0.3	3.6	0.77	96.8	82.9659	60.5602
2015	7	4	20	23	6	0.3	3.6	0.76	96.7	82.9659	59.525
2015	7	4	20	33	6	0.3	3.6	0.75	95.8	82.9659	59.0074
2015	7	4	20	43	6	0.3	3.6	0.75	97.1	82.9659	58.4898
2015	7	4	20	53	6	0.3	3.6	0.76	94	82.9659	59.5251
2015	7	4	21	3	6	0.3	3.6	0.75	98.1	82.9659	58.231
2015	7	4	21	13	6	0.3	3.6	0.78	96.5	83.0315	61.3874
2015	7	4	21	23	6	0.3	3.6	0.77	96.2	83.0315	60.0923
2015	7	4	21	33	6	0.3	3.6	0.73	96.5	83.0315	56.9841
2015	7	4	21	43	6	0.3	3.6	0.76	95.2	83.0315	60.0923
2015	7	4	21	53	6	0.3	3.6	0.75	96.5	83.0315	59.0562

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	4	22	3	6	0.3	3.6	0.77	93.9	83.0315	60.6104
2015	7	4	22	13	6	0.3	3.6	0.76	93.7	83.0315	60.0923
2015	7	4	22	23	6	0.3	3.6	0.74	94.6	83.0315	58.5382
2015	7	4	22	33	6	0.3	3.9	0.79	94.5	83.0971	62.4751
2015	7	4	22	43	6	0.3	3.6	0.76	97.5	83.0315	59.3153
2015	7	4	22	53	6	0.3	3.9	0.76	96	83.0971	59.6235
2015	7	4	23	3	6	0.3	3.9	0.76	97.5	83.0971	59.3643
2015	7	4	23	13	6	0.3	3.9	0.76	96.7	83.0971	59.6235
2015	7	4	23	23	6	0.3	3.9	0.78	96	83.0971	61.4382
2015	7	4	23	33	6	0.3	3.9	0.75	95.5	83.0971	58.8459
2015	7	4	23	43	6	0.3	3.9	0.76	96.2	83.0971	59.3643
2015	7	4	23	53	6	0.3	3.9	0.73	95.1	83.0971	57.8089
2015	7	5	0	3	6	0.3	3.9	0.77	96.1	83.0971	60.4013
2015	7	5	0	13	6	0.3	3.9	0.77	95.6	83.0971	60.4013
2015	7	5	0	23	6	0.3	3.9	0.77	94.9	83.0971	60.4013
2015	7	5	0	33	6	0.3	3.9	0.76	96.2	83.0971	59.8829
2015	7	5	0	43	6	0.3	3.9	0.79	96.7	83.0971	61.9567
2015	7	5	0	53	6	0.3	3.9	0.79	94.5	83.1627	62.0078
2015	7	5	1	3	6	0.3	3.9	0.74	94.3	83.0971	58.3275
2015	7	5	1	13	6	0.3	3.9	0.76	93.7	83.1627	60.1917
2015	7	5	1	23	6	0.3	3.9	0.75	94.8	83.1627	58.8945
2015	7	5	1	33	6	0.3	3.9	0.76	95.2	83.1627	59.6729
2015	7	5	1	43	6	0.3	3.9	0.75	94.5	83.1627	59.4134
2015	7	5	1	53	6	0.3	3.9	0.8	97.1	83.1627	62.5268
2015	7	5	2	3	6	0.3	3.9	0.76	95.4	83.1627	60.1918
2015	7	5	2	13	6	0.3	3.9	0.76	96.5	83.1627	59.4135
2015	7	5	2	23	6	0.3	3.9	0.73	96.2	83.1627	57.5974
2015	7	5	2	33	6	0.3	3.9	0.76	97.5	83.1627	59.4135
2015	7	5	2	43	6	0.3	3.9	0.76	95.2	83.1627	59.9324
2015	7	5	2	53	6	0.3	3.9	0.77	96.4	83.1627	60.1919
2015	7	5	3	3	6	0.3	3.9	0.75	95.3	83.1627	59.1541
2015	7	5	3	13	6	0.3	3.9	0.76	95.2	83.1627	60.1919
2015	7	5	3	23	6	0.3	3.9	0.75	95	83.1627	59.4136
2015	7	5	3	33	6	0.3	3.9	0.74	95.1	83.1627	58.1164
2015	7	5	3	43	6	0.3	3.9	0.79	96	83.1627	61.7487
2015	7	5	3	53	6	0.3	3.9	0.81	96.8	83.2284	63.3575
2015	7	5	4	3	6	0.3	3.9	0.78	94.1	83.2284	61.5399
2015	7	5	4	13	6	0.3	3.9	0.76	97.2	83.2284	59.982
2015	7	5	4	23	6	0.3	3.9	0.74	95.6	83.2284	57.9047
2015	7	5	4	33	6	0.3	3.9	0.75	96	83.2284	58.9434
2015	7	5	4	43	6	0.3	3.9	0.77	96.1	83.2284	60.5014
2015	7	5	4	53	6	0.3	3.9	0.78	95.3	83.2284	61.7997
2015	7	5	5	3	6	0.3	3.9	0.73	95.1	83.2284	57.6451
2015	7	5	5	13	6	0.3	3.9	0.77	97.8	83.2284	60.5014
2015	7	5	5	23	6	0.3	3.9	0.75	95.5	83.2284	59.2031
2015	7	5	5	33	6	0.3	3.9	0.8	96.6	83.2284	62.8384
2015	7	5	5	43	6	0.3	3.9	0.76	98.5	83.2284	59.2032

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	5	5	53	6	0.3	3.9	0.79	96.4	83.294	62.3704
2015	7	5	6	3	6	0.3	3.9	0.78	96.1	83.294	61.0711
2015	7	5	6	13	6	0.3	3.9	0.78	97.5	83.3596	61.6415
2015	7	5	6	23	6	0.3	3.9	0.77	98.6	83.3596	60.3411
2015	7	5	6	33	6	0.3	3.9	0.79	95.5	83.4908	62.264
2015	7	5	6	43	6	0.3	3.9	0.76	95.7	83.4908	59.6588
2015	7	5	6	53	6	0.3	3.9	0.77	96.1	83.4908	60.9614
2015	7	5	7	3	6	0.3	3.9	0.77	96.1	83.4908	60.7009
2015	7	5	7	13	6	0.3	3.9	0.8	96.8	83.5564	63.0974
2015	7	5	7	23	6	0.3	3.9	0.79	96.4	83.5564	62.5759
2015	7	5	7	33	6	0.3	3.9	0.74	97.6	83.5564	58.4042
2015	7	5	7	43	6	0.3	3.9	0.78	95.8	83.5564	61.7937
2015	7	5	7	53	6	0.3	3.9	0.76	96.4	83.5564	60.2293
2015	7	5	8	3	6	0.3	3.9	0.78	96.8	83.5564	61.2722
2015	7	5	8	13	6	0.3	3.9	0.73	94.4	83.5564	58.1434
2015	7	5	8	23	6	0.3	3.9	0.71	96.6	83.5564	56.3183
2015	7	5	8	33	6	0.3	3.9	0.78	95.5	83.5564	61.7937
2015	7	5	8	43	6	0.3	3.9	0.76	97.2	83.5564	59.9686
2015	7	5	8	53	6	0.3	3.9	0.78	98.2	83.5564	61.533
2015	7	5	9	3	6	0.3	3.9	0.73	95.1	83.5564	58.1434
2015	7	5	9	13	6	0.3	3.9	0.78	96.1	83.5564	61.2722
2015	7	5	9	23	6	0.3	3.9	0.8	98.5	83.5564	62.5759
2015	7	5	9	33	6	0.3	3.9	0.78	99.1	83.5564	61.5329
2015	7	5	9	43	6	0.3	3.9	0.77	94.7	83.5564	60.7507
2015	7	5	9	53	6	0.3	3.9	0.77	97.6	83.5564	60.4899
2015	7	5	10	3	6	0.3	3.9	0.77	97.3	83.5564	60.7507
2015	7	5	10	13	6	0.3	3.9	0.78	96.6	83.5564	61.2721
2015	7	5	10	23	6	0.3	3.9	0.76	99.4	83.5564	59.9684
2015	7	5	10	33	6	0.3	3.9	0.77	98.6	83.5564	60.2291
2015	7	5	10	43	6	0.3	3.9	0.76	98.5	83.5564	59.4469
2015	7	5	10	53	6	0.3	3.9	0.74	96.3	83.5564	58.6647
2015	7	5	11	3	6	0.3	3.9	0.74	95.6	83.5564	58.1432
2015	7	5	11	13	6	0.3	3.9	0.76	96.2	83.5564	59.7076
2015	7	5	11	23	6	0.3	3.9	0.74	97.9	83.4908	58.0955
2015	7	5	11	33	6	0.3	3.9	0.74	96.6	83.4252	58.3081
2015	7	5	11	43	6	0.3	3.9	0.74	96.4	83.3596	58.0001
2015	7	5	11	53	6	0.3	3.9	0.71	98.5	83.3596	55.9193
2015	7	5	12	3	6	0.3	3.9	0.72	94.2	83.294	57.1727
2015	7	5	12	13	6	0.3	3.9	0.75	97	83.294	58.9918
2015	7	5	12	23	6	0.3	3.9	0.76	95.7	83.294	60.0313
2015	7	5	12	33	6	0.3	3.9	0.71	98.2	83.294	55.6134
2015	7	5	12	43	6	0.3	3.9	0.74	96.1	83.294	57.9522
2015	7	5	12	53	6	0.3	3.9	0.75	96.3	83.294	59.2515
2015	7	5	13	3	6	0.3	3.9	0.73	98	83.2284	57.3852
2015	7	5	13	13	6	0.3	3.9	0.73	98.3	83.2284	57.1256
2015	7	5	13	23	6	0.3	3.9	0.78	96.3	83.2284	61.2802
2015	7	5	13	33	6	0.3	3.9	0.74	99.5	83.2284	57.6449

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	5	13	43	6	0.3	3.9	0.73	97	83.1627	57.0785
2015	7	5	13	53	6	0.3	3.9	0.72	95.8	83.1627	56.5596
2015	7	5	14	3	6	0.3	3.9	0.74	97.4	83.1627	57.8568
2015	7	5	14	13	6	0.3	3.9	0.79	96	83.2284	62.0591
2015	7	5	14	23	6	0.3	3.9	0.74	95.3	83.2284	58.4238
2015	7	5	14	33	6	0.3	3.9	0.74	99.5	83.1627	57.5974
2015	7	5	14	43	6	0.3	3.9	0.76	96.2	83.1627	59.673
2015	7	5	14	53	6	0.3	3.9	0.73	97.2	83.1627	57.3379
2015	7	5	15	3	6	0.3	3.9	0.75	94	83.1627	58.8946
2015	7	5	15	13	6	0.3	3.9	0.75	96	83.1627	59.1541
2015	7	5	15	23	6	0.3	3.9	0.76	94.7	83.1627	60.1919
2015	7	5	15	33	6	0.3	3.9	0.77	95.6	83.1627	60.4513
2015	7	5	15	43	6	0.3	3.9	0.74	96.4	83.1627	58.1163
2015	7	5	15	53	6	0.3	3.9	0.77	94.7	83.1627	60.4513
2015	7	5	16	3	6	0.3	3.9	0.72	93.6	83.0971	57.0314
2015	7	5	16	13	6	0.3	3.9	0.77	95.9	83.0971	60.4015
2015	7	5	16	23	6	0.3	3.9	0.75	94	83.0971	59.3645
2015	7	5	16	33	6	0.3	3.9	0.77	95.1	83.0971	60.6607
2015	7	5	16	43	6	0.3	3.9	0.74	97.1	83.0971	58.0684
2015	7	5	16	53	6	0.3	3.6	0.73	93.9	83.0315	57.5024
2015	7	5	17	3	6	0.3	3.9	0.77	98.3	83.1627	60.4513
2015	7	5	17	13	6	0.3	3.9	0.71	93.7	83.0971	56.2537
2015	7	5	17	23	6	0.3	3.9	0.73	95.4	83.0971	57.5499
2015	7	5	17	33	6	0.3	3.9	0.82	96	83.1627	64.6024
2015	7	5	17	43	6	0.3	3.9	0.72	96.5	83.0971	56.5129
2015	7	5	17	53	6	0.3	3.9	0.75	93.7	83.1627	59.4135
2015	7	5	18	3	6	0.3	3.9	0.79	96.7	83.0971	61.9568
2015	7	5	18	13	6	0.3	3.9	0.79	94.5	83.1627	62.2674
2015	7	5	18	23	6	0.3	3.9	0.76	94.2	83.1627	60.1918
2015	7	5	18	33	6	0.3	3.9	0.72	95.5	83.1627	56.5596
2015	7	5	18	43	6	0.3	3.9	0.77	95.9	83.1627	60.1918
2015	7	5	18	53	6	0.3	3.9	0.72	96.5	83.1627	56.5596
2015	7	5	19	3	6	0.3	3.9	0.77	95.9	83.1627	60.1919
2015	7	5	19	13	6	0.3	3.9	0.72	97.8	83.1627	56.5596
2015	7	5	19	23	6	0.3	3.9	0.76	95.7	83.1627	60.1919
2015	7	5	19	33	6	0.3	3.9	0.77	98.3	83.1627	60.4513
2015	7	5	19	43	6	0.3	3.9	0.75	97.6	83.1627	58.6352
2015	7	5	19	53	6	0.3	3.9	0.72	94.7	83.1627	56.5596
2015	7	5	20	3	6	0.3	3.9	0.78	95.1	83.1627	61.2297
2015	7	5	20	13	6	0.3	3.9	0.75	95.3	83.1627	58.8947
2015	7	5	20	23	6	0.3	3.9	0.8	98.3	83.1627	62.5269
2015	7	5	20	33	6	0.3	3.9	0.77	96.4	83.1627	60.1919
2015	7	5	20	43	6	0.3	3.9	0.78	97.7	83.1627	61.4891
2015	7	5	20	53	6	0.3	3.9	0.75	95.5	83.2284	58.9432
2015	7	5	21	3	6	0.3	3.9	0.76	97.7	83.2284	59.4625
2015	7	5	21	13	6	0.3	3.9	0.78	96.1	83.2284	61.0205
2015	7	5	21	23	6	0.3	3.9	0.79	95.9	83.2284	62.3188

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	5	21	33	6	0.3	3.9	0.76	94.2	83.2284	59.7222
2015	7	5	21	43	6	0.3	3.9	0.74	96.3	83.2284	58.4239
2015	7	5	21	53	6	0.3	3.9	0.77	96.3	83.2284	60.7609
2015	7	5	22	3	6	0.3	3.9	0.8	97.1	83.2284	62.5785
2015	7	5	22	13	6	0.3	3.9	0.82	97.8	83.2284	64.1365
2015	7	5	22	23	6	0.3	3.9	0.79	96.2	83.2284	62.0592
2015	7	5	22	33	6	0.3	3.9	0.75	98.3	83.2284	58.6836
2015	7	5	22	43	6	0.3	3.9	0.77	98.8	83.294	60.2912
2015	7	5	22	53	6	0.3	3.9	0.73	96.4	83.294	57.6925
2015	7	5	23	3	6	0.3	3.9	0.77	96.2	83.294	60.2912
2015	7	5	23	13	6	0.3	3.9	0.76	97.2	83.294	59.7715
2015	7	5	23	23	6	0.3	3.9	0.75	98.6	83.3596	58.5202
2015	7	5	23	33	6	0.3	3.9	0.74	96.3	83.4252	58.5683
2015	7	5	23	43	6	0.3	3.9	0.75	97.8	83.4908	59.1375
2015	7	5	23	53	6	0.3	3.9	0.76	97.4	83.4908	60.1796
2015	7	6	0	3	6	0.3	3.9	0.75	99.3	83.5564	58.9253
2015	7	6	0	13	6	0.3	3.9	0.76	97.4	83.5564	60.229
2015	7	6	0	23	6	0.3	3.9	0.74	96.6	83.5564	58.4039
2015	7	6	0	33	6	0.3	3.9	0.76	97.4	83.5564	60.229
2015	7	6	0	43	6	0.3	3.9	0.83	93.8	83.6221	66.0192
2015	7	6	0	53	6	0.3	3.9	0.77	99	83.6221	60.8003
2015	7	6	1	3	6	0.3	3.9	0.79	93.6	83.6221	62.6269
2015	7	6	1	13	6	0.3	3.9	0.73	95.9	83.6221	57.669
2015	7	6	1	23	6	0.3	3.9	0.75	97.1	83.6221	58.9737
2015	7	6	1	33	6	0.3	3.9	0.78	98.5	83.6221	61.0613
2015	7	6	1	43	6	0.3	3.9	0.78	94.6	83.6221	62.1051
2015	7	6	1	53	6	0.3	3.9	0.76	96.2	83.6877	59.8056
2015	7	6	2	3	6	0.3	3.9	0.76	97.7	83.6877	59.8056
2015	7	6	2	13	6	0.3	3.9	0.79	95.7	83.6877	62.9395
2015	7	6	2	23	6	0.3	3.9	0.77	95.6	83.6877	61.1114
2015	7	6	2	33	6	0.3	3.9	0.78	96.3	83.6877	61.6337
2015	7	6	2	43	6	0.3	3.9	0.76	96.5	83.6877	59.8056
2015	7	6	2	53	6	0.3	3.9	0.8	95.6	83.6877	63.7231
2015	7	6	3	3	6	0.3	3.9	0.75	97.8	83.6877	58.761
2015	7	6	3	13	6	0.3	3.9	0.78	96.6	83.6877	61.3727
2015	7	6	3	23	6	0.3	3.9	0.77	96.1	83.6877	60.8504
2015	7	6	3	33	6	0.3	3.9	0.77	95.6	83.6877	61.1115
2015	7	6	3	43	6	0.3	3.9	0.78	94.1	83.7533	61.6843
2015	7	6	3	53	6	0.3	3.9	0.76	96.2	83.6877	60.0669
2015	7	6	4	3	6	0.3	3.9	0.78	97.3	83.6877	61.3728
2015	7	6	4	13	6	0.3	3.9	0.75	97	83.7533	59.332
2015	7	6	4	23	6	0.3	3.9	0.83	95.7	83.6877	65.5514
2015	7	6	4	33	6	0.3	3.9	0.75	98.8	83.7533	58.8093
2015	7	6	4	43	6	0.3	3.9	0.78	96.5	83.6877	61.634
2015	7	6	4	53	6	0.3	3.9	0.76	96.2	83.7533	60.1162
2015	7	6	5	3	6	0.3	3.9	0.78	95.8	83.6877	61.3729
2015	7	6	5	13	6	0.3	3.9	0.78	94.6	83.6877	62.1564

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	6	5	23	6	0.3	3.9	0.8	94.7	83.6877	63.4622
2015	7	6	5	33	6	0.3	3.9	0.79	96.7	83.6877	62.6788
2015	7	6	5	43	6	0.3	3.9	0.79	96.7	83.7533	62.4687
2015	7	6	5	53	6	0.3	3.9	0.75	96.8	83.6877	59.5449
2015	7	6	6	3	6	0.3	3.9	0.76	95.5	83.6877	60.0672
2015	7	6	6	13	6	0.3	3.9	0.78	99.7	83.6877	61.1119
2015	7	6	6	23	6	0.3	3.9	0.77	94.9	83.6877	61.3731
2015	7	6	6	33	6	0.3	3.9	0.75	94.5	83.7533	59.3324
2015	7	6	6	43	6	0.3	3.9	0.76	95.9	83.7533	60.3779
2015	7	6	6	53	6	0.3	3.9	0.78	98.2	83.7533	61.4234
2015	7	6	7	3	6	0.3	3.9	0.76	96	83.7533	59.8552
2015	7	6	7	13	6	0.3	3.9	0.78	97	83.7533	61.6848
2015	7	6	7	23	6	0.3	3.9	0.76	97.7	83.7533	60.1166
2015	7	6	7	33	6	0.3	3.9	0.76	97.2	83.7533	60.3779
2015	7	6	7	43	6	0.3	3.9	0.77	94.9	83.7533	60.9007
2015	7	6	7	53	6	0.3	3.9	0.76	95.7	83.7533	60.6393
2015	7	6	8	3	6	0.3	3.9	0.75	96	83.7533	59.5938
2015	7	6	8	13	6	0.3	3.9	0.75	97.5	83.7533	59.3324
2015	7	6	8	23	6	0.3	3.9	0.79	95.7	83.7533	62.9917
2015	7	6	8	33	6	0.3	3.9	0.77	94.9	83.7533	61.4235
2015	7	6	8	43	6	0.3	3.9	0.77	96.3	83.7533	61.1621
2015	7	6	8	53	6	0.3	3.9	0.75	97.8	83.7533	58.8097
2015	7	6	9	3	6	0.3	3.9	0.81	98.7	83.7533	63.5144
2015	7	6	9	13	6	0.3	3.9	0.76	95.2	83.7533	60.1165
2015	7	6	9	23	6	0.3	3.9	0.74	96.4	83.7533	58.5483
2015	7	6	9	33	6	0.3	3.9	0.76	96.7	83.7533	60.3779
2015	7	6	9	43	6	0.3	3.9	0.74	96.6	83.7533	58.8096
2015	7	6	9	53	6	0.3	3.9	0.74	96.4	83.7533	58.2868
2015	7	6	10	3	6	0.3	3.9	0.77	95.4	83.7533	60.9006
2015	7	6	10	13	6	0.3	3.9	0.73	96.2	83.7533	57.764
2015	7	6	10	23	6	0.3	3.9	0.81	96.1	83.7533	63.7757
2015	7	6	10	33	6	0.3	3.9	0.77	97.6	83.7533	60.6391
2015	7	6	10	43	6	0.3	3.9	0.75	96	83.7533	59.5936
2015	7	6	10	53	6	0.3	3.9	0.75	98.1	83.7533	59.0708
2015	7	6	11	3	6	0.3	3.9	0.76	94.7	83.7533	60.3777
2015	7	6	11	13	6	0.3	3.9	0.79	97.4	83.7533	62.4687
2015	7	6	11	23	6	0.3	3.9	0.78	98.4	83.7533	61.6845
2015	7	6	11	33	6	0.3	3.9	0.73	96.5	83.7533	57.5025
2015	7	6	11	43	6	0.3	3.9	0.77	95.1	83.7533	61.1617
2015	7	6	11	53	6	0.3	3.9	0.71	95.6	83.7533	56.4569
2015	7	6	12	3	6	0.3	3.9	0.72	98.2	83.7533	56.4569
2015	7	6	12	13	6	0.3	3.9	0.74	98.4	83.7533	58.5479
2015	7	6	12	23	6	0.3	3.9	0.77	99.8	83.7533	60.6388
2015	7	6	12	33	6	0.3	3.9	0.73	98.6	83.7533	57.241
2015	7	6	12	43	6	0.3	3.9	0.73	99	83.7533	57.5023
2015	7	6	12	53	6	0.3	3.9	0.73	97.2	83.7533	58.0251
2015	7	6	13	3	6	0.3	3.9	0.75	97.2	83.7533	59.5933

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	6	13	13	6	0.3	3.9	0.75	98.8	83.7533	58.8092
2015	7	6	13	23	6	0.3	3.9	0.71	98.2	83.7533	56.1954
2015	7	6	13	33	6	0.3	3.9	0.76	97.7	83.7533	60.116
2015	7	6	13	43	6	0.3	3.9	0.77	97.3	83.7533	60.9
2015	7	6	13	53	6	0.3	3.9	0.77	97.3	83.7533	61.1614
2015	7	6	14	3	6	0.3	3.9	0.76	96.5	83.7533	59.8545
2015	7	6	14	13	6	0.3	3.9	0.79	95.5	83.7533	62.4682
2015	7	6	14	23	6	0.3	3.9	0.7	97.2	83.7533	55.6725
2015	7	6	14	33	6	0.3	3.9	0.78	97.2	83.6877	61.6336
2015	7	6	14	43	6	0.3	3.9	0.77	96.2	83.6877	60.589
2015	7	6	14	53	6	0.3	3.9	0.76	94.7	83.6877	60.0666
2015	7	6	15	3	6	0.3	3.9	0.76	96.7	83.6877	60.0666
2015	7	6	15	13	6	0.3	3.9	0.74	96.4	83.6877	58.2385
2015	7	6	15	23	6	0.3	3.9	0.77	95.9	83.6877	60.8502
2015	7	6	15	33	6	0.3	3.9	0.75	96.3	83.6877	59.2832
2015	7	6	15	43	6	0.3	3.9	0.75	98.3	83.6877	59.2832
2015	7	6	15	53	6	0.3	3.9	0.77	95.4	83.6877	60.8502
2015	7	6	16	3	6	0.3	3.9	0.73	98	83.6877	57.4551
2015	7	6	16	13	6	0.3	3.9	0.79	97.2	83.6877	62.4171
2015	7	6	16	23	6	0.3	3.9	0.76	97.2	83.6877	60.0667
2015	7	6	16	33	6	0.3	3.9	0.75	99.1	83.6877	59.022
2015	7	6	16	43	6	0.3	3.9	0.77	96.1	83.6877	60.8501
2015	7	6	16	53	6	0.3	3.9	0.75	97	83.6877	59.2832
2015	7	6	17	3	6	0.3	3.9	0.74	93.3	83.6877	58.4997
2015	7	6	17	13	6	0.3	3.9	0.73	95.9	83.6877	57.9774
2015	7	6	17	23	6	0.3	3.9	0.78	95.8	83.7533	61.4227
2015	7	6	17	33	6	0.3	3.9	0.75	97.2	83.7533	59.5931
2015	7	6	17	43	6	0.3	3.9	0.78	96.8	83.7533	61.6841
2015	7	6	17	53	6	0.3	3.9	0.81	96.7	83.7533	64.2978
2015	7	6	18	3	6	0.3	3.9	0.79	96.7	83.7533	62.4682
2015	7	6	18	13	6	0.3	3.9	0.75	96.3	83.7533	59.5931
2015	7	6	18	23	6	0.3	3.9	0.77	94.9	83.7533	60.9
2015	7	6	18	33	6	0.3	3.9	0.76	97.5	83.7533	59.8545
2015	7	6	18	43	6	0.3	3.9	0.74	96.4	83.7533	58.5476
2015	7	6	18	53	6	0.3	3.9	0.79	96.5	83.7533	62.2068
2015	7	6	19	3	6	0.3	3.9	0.78	95.6	83.7533	61.6841
2015	7	6	19	13	6	0.3	3.9	0.77	94.4	83.7533	61.1613
2015	7	6	19	23	6	0.3	3.9	0.79	98.3	83.7533	62.4682
2015	7	6	19	33	6	0.3	3.9	0.77	96.1	83.7533	60.9
2015	7	6	19	43	6	0.3	3.9	0.8	96.2	83.8189	63.0425
2015	7	6	19	53	6	0.3	3.9	0.75	97.2	83.8189	59.6419
2015	7	6	20	3	6	0.3	3.9	0.79	99.3	83.8189	62.2577
2015	7	6	20	13	6	0.3	3.9	0.74	96.1	83.8189	58.8571
2015	7	6	20	23	6	0.3	3.9	0.77	96.6	83.8189	60.9498
2015	7	6	20	33	6	0.3	3.9	0.78	92.7	83.8189	61.9962
2015	7	6	20	43	6	0.3	3.9	0.74	96.4	83.8189	58.3339
2015	7	6	20	53	6	0.3	3.9	0.78	97	83.8189	61.473

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	6	21	3	6	0.3	3.9	0.76	93.7	83.8189	60.4267
2015	7	6	21	13	6	0.3	3.9	0.77	98.1	83.8189	60.6882
2015	7	6	21	23	6	0.3	3.9	0.78	97.2	83.8189	61.9962
2015	7	6	21	33	6	0.3	3.9	0.84	94.3	83.8189	66.4432
2015	7	6	21	43	6	0.3	3.9	0.78	95.1	83.8189	61.9962
2015	7	6	21	53	6	0.3	3.9	0.74	96.4	83.8845	58.3817
2015	7	6	22	3	6	0.3	3.9	0.75	94	83.8845	59.4289
2015	7	6	22	13	6	0.3	3.9	0.79	95.2	83.8845	62.8323
2015	7	6	22	23	6	0.3	3.9	0.75	96.3	83.8845	59.4289
2015	7	6	22	33	6	0.3	3.9	0.75	93.7	83.8845	59.9525
2015	7	6	22	43	6	0.3	3.9	0.75	93.7	83.8845	59.9525
2015	7	6	22	53	6	0.3	3.9	0.76	98	83.9501	59.7394
2015	7	6	23	3	6	0.3	3.9	0.76	97	83.9501	60.0015
2015	7	6	23	13	6	0.3	3.9	0.75	97.6	83.9501	59.2154
2015	7	6	23	23	6	0.3	3.9	0.79	94.7	83.9501	63.1456
2015	7	6	23	33	6	0.3	3.9	0.75	97.2	83.9501	59.7395
2015	7	6	23	43	6	0.3	3.9	0.79	95.9	83.9501	62.8836
2015	7	6	23	53	6	0.3	3.9	0.79	96.7	84.0158	62.6727
2015	7	7	0	3	6	0.3	3.9	0.8	95.2	84.0158	63.7216
2015	7	7	0	13	6	0.3	3.9	0.8	97.6	84.0158	63.1972
2015	7	7	0	23	6	0.3	3.9	0.76	97.9	84.0158	60.3127
2015	7	7	0	33	6	0.3	3.9	0.79	94	84.0814	63.2487
2015	7	7	0	43	6	0.3	3.9	0.8	96.2	84.147	63.3003
2015	7	7	0	53	6	0.3	3.9	0.76	94.9	84.2126	60.986
2015	7	7	1	3	6	0.3	3.9	0.74	95.9	84.2782	58.9309
2015	7	7	1	13	6	0.3	3.9	0.79	95	84.3438	63.4549
2015	7	7	1	23	6	0.3	3.9	0.77	97.4	84.3438	61.0852
2015	7	7	1	33	6	0.3	3.9	0.78	97.2	84.3438	62.1384
2015	7	7	1	43	6	0.3	3.9	0.82	95.7	84.3438	65.8246
2015	7	7	1	53	6	0.3	3.9	0.78	96	84.4095	62.1889
2015	7	7	2	3	6	0.3	3.9	0.76	95.7	84.4095	61.1348
2015	7	7	2	13	6	0.3	3.9	0.83	94.6	84.4095	66.1416
2015	7	7	2	23	6	0.3	3.9	0.74	95.6	84.4751	59.3384
2015	7	7	2	33	6	0.3	3.9	0.78	96.3	84.4751	62.2394
2015	7	7	2	43	6	0.3	3.9	0.8	96.2	84.4751	63.558
2015	7	7	2	53	6	0.3	3.9	0.79	97.7	84.4751	62.7669
2015	7	7	3	3	6	0.3	3.9	0.76	94.7	84.5407	60.7063
2015	7	7	3	13	6	0.3	3.9	0.79	97.1	84.5407	63.3457
2015	7	7	3	23	6	0.3	3.9	0.75	94	84.5407	60.4423
2015	7	7	3	33	6	0.3	3.9	0.81	95.3	84.5407	64.9293
2015	7	7	3	43	6	0.3	3.9	0.76	96.2	84.5407	60.9702
2015	7	7	3	53	6	0.3	3.9	0.81	96.3	84.5407	64.6654
2015	7	7	4	3	6	0.3	3.9	0.81	97.2	84.5407	64.9294
2015	7	7	4	13	6	0.3	3.9	0.77	96.4	84.6063	61.2839
2015	7	7	4	23	6	0.3	3.9	0.74	94.1	84.6063	59.1706
2015	7	7	4	33	6	0.3	3.9	0.73	95.4	84.6063	58.3782
2015	7	7	4	43	6	0.3	3.9	0.79	95.9	84.6063	63.6613

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	7	4	53	6	0.3	3.9	0.76	94.7	84.6063	60.7556
2015	7	7	5	3	6	0.3	3.9	0.76	97.4	84.6719	61.0692
2015	7	7	5	13	6	0.3	3.9	0.78	96.8	84.6719	62.1267
2015	7	7	5	23	6	0.3	3.9	0.75	97.6	84.6719	59.7474
2015	7	7	5	33	6	0.3	3.9	0.83	96.6	84.6719	66.0923
2015	7	7	5	43	6	0.3	3.9	0.79	94.5	84.7375	63.7645
2015	7	7	5	53	6	0.3	3.9	0.78	95.3	84.7375	62.9708
2015	7	7	6	3	6	0.3	3.9	0.78	96.8	84.8032	62.2273
2015	7	7	6	13	6	0.3	3.9	0.76	95.2	84.8688	60.9525
2015	7	7	6	23	6	0.3	3.9	0.76	96.2	85	60.7855
2015	7	7	6	33	6	0.3	3.9	0.81	95.6	85	65.298
2015	7	7	6	43	6	0.3	3.9	0.8	96.4	85.0656	64.0224
2015	7	7	6	53	6	0.3	3.9	0.74	97.3	85.0656	59.772
2015	7	7	7	3	6	0.3	3.9	0.78	96.1	85.0656	62.4285
2015	7	7	7	13	6	0.3	3.9	0.78	96.1	85.1312	62.4788
2015	7	7	7	23	6	0.3	3.9	0.78	95.3	85.1312	62.7446
2015	7	7	7	33	6	0.3	3.9	0.78	97.3	85.1312	62.4788
2015	7	7	7	43	6	0.3	3.9	0.8	96.8	85.1312	64.6057
2015	7	7	7	53	6	0.3	3.9	0.8	94.5	85.1969	64.9238
2015	7	7	8	3	6	0.3	3.9	0.79	97.6	85.1969	63.5934
2015	7	7	8	13	6	0.3	3.9	0.81	96.8	85.1969	64.9238
2015	7	7	8	23	6	0.3	3.9	0.8	95.2	85.1969	64.9238
2015	7	7	8	33	6	0.3	3.9	0.83	95.5	85.1969	66.7863
2015	7	7	8	43	6	0.3	3.9	0.77	97.1	85.2625	62.313
2015	7	7	8	53	6	0.3	3.9	0.79	95.9	85.2625	64.1771
2015	7	7	9	3	6	0.3	3.9	0.78	97.2	85.2625	63.1119
2015	7	7	9	13	6	0.3	3.9	0.8	95	85.2625	64.4434
2015	7	7	9	23	6	0.3	3.9	0.79	94.7	85.2625	64.177
2015	7	7	9	33	6	0.3	3.9	0.77	98.5	85.2625	62.0467
2015	7	7	9	43	6	0.3	3.9	0.78	98.2	85.3281	62.6295
2015	7	7	9	53	6	0.3	3.9	0.78	96.1	85.3281	62.6295
2015	7	7	10	3	6	0.3	3.9	0.76	98.7	85.3281	60.7639
2015	7	7	10	13	6	0.3	3.9	0.78	98.5	85.3281	62.6295
2015	7	7	10	23	6	0.3	3.9	0.78	97.7	85.3281	62.8959
2015	7	7	10	33	6	0.3	3.9	0.78	94.8	85.3281	62.8959
2015	7	7	10	43	6	0.3	3.9	0.76	97.4	85.3281	61.2969
2015	7	7	10	53	6	0.3	3.9	0.74	95.3	85.3281	60.2308
2015	7	7	11	3	6	0.3	3.9	0.75	97.3	85.3937	60.2791
2015	7	7	11	13	6	0.3	3.9	0.75	96.5	85.3937	60.5458
2015	7	7	11	23	6	0.3	3.9	0.76	96.2	85.3281	61.0302
2015	7	7	11	33	6	0.3	3.9	0.74	98.7	85.3937	59.4789
2015	7	7	11	43	6	0.3	3.9	0.79	93.3	85.3937	64.0131
2015	7	7	11	53	6	0.3	3.9	0.73	95.7	85.4593	58.7258
2015	7	7	12	3	6	0.3	3.9	0.75	97.2	85.4593	60.8612
2015	7	7	12	13	6	0.3	3.9	0.73	96.2	85.3937	58.9454
2015	7	7	12	23	6	0.3	3.9	0.75	96.6	85.4593	60.3273
2015	7	7	12	33	6	0.3	3.9	0.72	97.3	85.4593	58.4587

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	7	12	43	6	0.3	3.9	0.75	95	85.4593	60.5942
2015	7	7	12	53	6	0.3	3.9	0.76	97.5	85.4593	61.128
2015	7	7	13	3	6	0.3	3.9	0.78	96	85.4593	63.2635
2015	7	7	13	13	6	0.3	3.9	0.76	95.2	85.4593	61.6619
2015	7	7	13	23	6	0.3	3.9	0.74	95.4	85.4593	59.7933
2015	7	7	13	33	6	0.3	3.9	0.74	94.8	85.4593	60.0602
2015	7	7	13	43	6	0.3	3.9	0.78	97	85.5249	63.3141
2015	7	7	13	53	6	0.3	3.9	0.75	95.8	85.4593	60.3271
2015	7	7	14	3	6	0.3	3.9	0.75	95.3	85.4593	60.594
2015	7	7	14	13	6	0.3	3.9	0.73	96.5	85.5249	58.7725
2015	7	7	14	23	6	0.3	3.9	0.71	96.1	85.4593	57.6577
2015	7	7	14	33	6	0.3	3.9	0.73	96.2	85.4593	58.7255
2015	7	7	14	43	6	0.3	3.9	0.72	96.3	85.4593	57.9246
2015	7	7	14	53	6	0.3	3.9	0.74	97.9	85.4593	59.2593
2015	7	7	15	3	6	0.3	3.9	0.73	95.4	85.4593	59.2593
2015	7	7	15	13	6	0.3	3.9	0.78	95.8	85.4593	63.5302
2015	7	7	15	23	6	0.3	3.9	0.77	95.9	85.4593	61.9286
2015	7	7	15	33	6	0.3	3.9	0.73	95.4	85.4593	59.2593
2015	7	7	15	43	6	0.3	3.9	0.73	97.2	85.4593	59.2593
2015	7	7	15	53	6	0.3	3.9	0.78	94.8	85.4593	63.2633
2015	7	7	16	3	6	0.3	3.9	0.77	97.3	85.4593	62.1955
2015	7	7	16	13	6	0.3	3.9	0.74	96.4	85.4593	59.5262
2015	7	7	16	23	6	0.3	3.9	0.74	94.6	85.4593	59.7931
2015	7	7	16	33	6	0.3	3.9	0.73	97.4	85.4593	59.2593
2015	7	7	16	43	6	0.3	3.9	0.77	97.1	85.4593	61.9286
2015	7	7	16	53	6	0.3	3.9	0.7	100.2	85.4593	56.323
2015	7	7	17	3	6	0.3	3.9	0.75	97.5	85.4593	60.8609
2015	7	7	17	13	6	0.3	3.9	0.71	96.6	85.4593	57.6577
2015	7	7	17	23	6	0.3	3.9	0.75	96.3	85.4593	60.594
2015	7	7	17	33	6	0.3	3.9	0.76	98.5	85.4593	60.8609
2015	7	7	17	43	6	0.3	3.9	0.75	96	85.4593	60.8609
2015	7	7	17	53	6	0.3	3.9	0.72	97.4	85.4593	57.9247
2015	7	7	18	3	6	0.3	3.9	0.73	94.6	85.4593	59.2593
2015	7	7	18	13	6	0.3	3.9	0.79	97.2	85.4593	63.7972
2015	7	7	18	23	6	0.3	3.9	0.73	97.5	85.4593	58.7255
2015	7	7	18	33	6	0.3	3.9	0.76	95.4	85.4593	61.9287
2015	7	7	18	43	6	0.3	3.9	0.76	96.9	85.4593	61.6618
2015	7	7	18	53	6	0.3	3.9	0.73	98	85.4593	58.9924
2015	7	7	19	3	6	0.3	3.9	0.75	98	85.4593	60.594
2015	7	7	19	13	6	0.3	3.9	0.74	95.1	85.4593	59.7933
2015	7	7	19	23	6	0.3	3.9	0.77	96.6	85.4593	62.1957
2015	7	7	19	33	6	0.3	3.9	0.76	97.2	85.4593	61.3949
2015	7	7	19	43	6	0.3	3.9	0.72	97.9	85.4593	57.9247
2015	7	7	19	53	6	0.3	3.9	0.78	95.8	85.4593	63.5304
2015	7	7	20	3	6	0.3	3.9	0.73	99	85.4593	58.9925
2015	7	7	20	13	6	0.3	3.9	0.8	97.1	85.4593	64.3312
2015	7	7	20	23	6	0.3	3.9	0.82	98.1	85.5249	65.9856

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	7	20	33	6	0.3	3.9	0.8	95.9	85.5249	64.917
2015	7	7	20	43	6	0.3	3.9	0.78	96	85.5249	63.047
2015	7	7	20	53	6	0.3	3.9	0.76	92.5	85.5249	61.7113
2015	7	7	21	3	6	0.3	3.9	0.79	94.5	85.5249	64.3828
2015	7	7	21	13	6	0.3	3.9	0.75	92.3	85.5249	60.9098
2015	7	7	21	23	6	0.3	3.9	0.77	94.6	85.5249	62.7799
2015	7	7	21	33	6	0.3	3.9	0.8	95.2	85.5249	64.9171
2015	7	7	21	43	6	0.3	3.9	0.82	97.6	85.5906	66.0385
2015	7	7	21	53	6	0.3	3.9	0.75	96.8	85.5906	60.6913
2015	7	7	22	3	6	0.3	3.9	0.83	96.3	85.5906	67.3754
2015	7	7	22	13	6	0.3	3.9	0.77	97.3	85.5906	62.5628
2015	7	7	22	23	6	0.3	3.9	0.83	94.8	85.5906	67.108
2015	7	7	22	33	6	0.3	3.9	0.79	96.5	85.6562	63.6832
2015	7	7	22	43	6	0.3	3.9	0.8	95.9	85.7218	64.8053
2015	7	7	22	53	6	0.3	3.9	0.79	95.2	85.7874	64.5891
2015	7	7	23	3	6	0.3	3.9	0.71	95.6	85.853	57.9352
2015	7	7	23	13	6	0.3	3.9	0.77	95.1	85.7874	62.7131
2015	7	7	23	23	6	0.3	3.9	0.77	98.1	85.853	62.2268
2015	7	7	23	33	6	0.3	3.9	0.81	97.9	85.7218	65.8765
2015	7	7	23	43	6	0.3	3.9	0.79	97.6	85.853	64.3725
2015	7	7	23	53	6	0.3	3.9	0.78	96.1	85.853	63.0314
2015	7	8	0	3	6	0.3	3.9	0.81	95.6	85.9186	65.7661
2015	7	8	0	13	6	0.3	3.9	0.79	94.7	85.9186	64.6923
2015	7	8	0	23	6	0.3	3.9	0.78	96.7	85.9186	63.6186
2015	7	8	0	33	6	0.3	3.9	0.78	95.1	85.9843	63.6693
2015	7	8	0	43	6	0.3	3.9	0.77	97.5	85.9843	62.8634
2015	7	8	0	53	6	0.3	3.9	0.8	96.2	85.9843	64.7439
2015	7	8	1	3	6	0.3	3.9	0.79	95.5	85.9843	64.7439
2015	7	8	1	13	6	0.3	3.9	0.8	95.4	85.9843	65.5499
2015	7	8	1	23	6	0.3	3.9	0.81	96.3	85.9843	66.0872
2015	7	8	1	33	6	0.3	3.9	0.82	97.6	85.9843	66.3558
2015	7	8	1	43	6	0.3	3.9	0.76	96.2	85.9843	62.0575
2015	7	8	1	53	6	0.3	3.9	0.78	96	86.0499	63.4512
2015	7	8	2	3	6	0.3	3.9	0.81	95.6	85.9843	66.0872
2015	7	8	2	13	6	0.3	3.9	0.8	96.1	86.0499	65.0644
2015	7	8	2	23	6	0.3	3.9	0.8	95.7	86.0499	65.0644
2015	7	8	2	33	6	0.3	3.9	0.81	94.4	86.0499	66.1399
2015	7	8	2	43	6	0.3	3.9	0.78	94.8	86.0499	63.4513
2015	7	8	2	53	6	0.3	3.9	0.81	96.1	86.0499	65.6022
2015	7	8	3	3	6	0.3	3.9	0.78	96.3	86.0499	63.7201
2015	7	8	3	13	6	0.3	3.9	0.78	94.8	86.0499	63.7202
2015	7	8	3	23	6	0.3	3.9	0.78	93.4	86.0499	63.989
2015	7	8	3	33	6	0.3	3.9	0.85	96.9	86.0499	69.0974
2015	7	8	3	43	6	0.3	3.9	0.74	94.1	86.0499	60.225
2015	7	8	3	53	6	0.3	3.9	0.77	97.9	86.0499	62.107
2015	7	8	4	3	6	0.3	3.9	0.84	97	86.0499	68.2909
2015	7	8	4	13	6	0.3	3.9	0.81	96.5	86.0499	65.6023

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	8	4	23	6	0.3	3.9	0.81	96.8	86.0499	65.8711
2015	7	8	4	33	6	0.3	3.9	0.8	94.2	86.0499	65.6023
2015	7	8	4	43	6	0.3	3.9	0.8	95.9	86.0499	65.3334
2015	7	8	4	53	6	0.3	3.9	0.76	94.4	86.0499	62.376
2015	7	8	5	3	6	0.3	3.9	0.77	94.7	86.0499	62.6449
2015	7	8	5	13	6	0.3	3.9	0.77	97.1	86.0499	62.6449
2015	7	8	5	23	6	0.3	3.9	0.79	94.5	86.0499	64.5269
2015	7	8	5	33	6	0.3	3.9	0.81	95.8	86.1155	65.9237
2015	7	8	5	43	6	0.3	3.9	0.81	97.7	86.0499	65.6024
2015	7	8	5	53	6	0.3	3.9	0.77	95.1	86.0499	62.9138
2015	7	8	6	3	6	0.3	3.9	0.79	94.3	86.1155	64.5783
2015	7	8	6	13	6	0.3	3.9	0.81	93.3	86.1155	65.9237
2015	7	8	6	23	6	0.3	3.9	0.76	95.2	86.1155	61.8876
2015	7	8	6	33	6	0.3	3.9	0.8	94.7	86.1155	65.6547
2015	7	8	6	43	6	0.3	3.9	0.84	97.2	86.1155	68.0764
2015	7	8	6	53	6	0.3	3.9	0.79	96.4	86.1155	64.3094
2015	7	8	7	3	6	0.3	3.9	0.8	99.5	86.1155	64.3094
2015	7	8	7	13	6	0.3	3.9	0.78	98.2	86.1155	63.5022
2015	7	8	7	23	6	0.3	3.9	0.8	95.9	86.1155	65.3857
2015	7	8	7	33	6	0.3	3.9	0.77	94.9	86.1155	63.2331
2015	7	8	7	43	6	0.3	3.9	0.81	96.7	86.1811	66.2456
2015	7	8	7	53	6	0.3	3.9	0.8	95.9	86.1155	65.6548
2015	7	8	8	3	6	0.3	3.9	0.78	98.2	86.1811	63.5527
2015	7	8	8	13	6	0.3	3.9	0.81	96.5	86.1811	65.707
2015	7	8	8	23	6	0.3	3.9	0.76	96.2	86.1811	61.6677
2015	7	8	8	33	6	0.3	3.9	0.8	96.4	86.1811	64.8991
2015	7	8	8	43	6	0.3	3.9	0.82	97.1	86.1811	67.0535
2015	7	8	8	53	6	0.3	3.9	0.84	96	86.1811	68.9385
2015	7	8	9	3	6	0.3	3.9	0.82	96.9	86.1811	66.7842
2015	7	8	9	13	6	0.3	3.9	0.8	96.8	86.1811	65.4377
2015	7	8	9	23	6	0.3	3.9	0.79	93.6	86.1811	64.6299
2015	7	8	9	33	6	0.3	3.9	0.76	94.5	86.1811	61.9369
2015	7	8	9	43	6	0.3	3.9	0.79	97.2	86.2467	64.4116
2015	7	8	9	53	6	0.3	3.9	0.79	96.7	86.2467	64.6811
2015	7	8	10	3	6	0.3	3.9	0.77	97.9	86.2467	62.2556
2015	7	8	10	13	6	0.3	3.9	0.81	96.5	86.2467	66.0286
2015	7	8	10	23	6	0.3	3.9	0.76	98.4	86.2467	61.7165
2015	7	8	10	33	6	0.3	3.9	0.79	97.6	86.2467	64.4115
2015	7	8	10	43	6	0.3	3.9	0.73	97	86.2467	59.5604
2015	7	8	10	53	6	0.3	3.9	0.78	98.5	86.2467	63.3335
2015	7	8	11	3	6	0.3	3.9	0.79	97.2	86.2467	64.142
2015	7	8	11	13	6	0.3	3.9	0.77	94.6	86.2467	63.3334
2015	7	8	11	23	6	0.3	3.9	0.81	96.5	86.2467	66.0284
2015	7	8	11	33	6	0.3	3.9	0.78	95.5	86.2467	63.8724
2015	7	8	11	43	6	0.3	3.9	0.83	95.4	86.2467	68.1844
2015	7	8	11	53	6	0.3	3.9	0.77	95.1	86.2467	63.0638
2015	7	8	12	3	6	0.3	3.9	0.8	98.5	86.2467	65.2198

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	8	12	13	6	0.3	3.9	0.77	96.8	86.3123	63.1139
2015	7	8	12	23	6	0.3	3.9	0.76	97	86.3123	61.7653
2015	7	8	12	33	6	0.3	3.9	0.78	94.8	86.3123	64.1927
2015	7	8	12	43	6	0.3	3.9	0.76	95.7	86.3123	62.3046
2015	7	8	12	53	6	0.3	3.9	0.75	94.5	86.2467	61.7162
2015	7	8	13	3	6	0.3	3.9	0.76	96.2	86.3123	62.3046
2015	7	8	13	13	6	0.3	3.9	0.75	97	86.2467	61.1771
2015	7	8	13	23	6	0.3	3.9	0.76	94.7	86.3123	62.5743
2015	7	8	13	33	6	0.3	3.9	0.77	98.3	86.2467	62.7942
2015	7	8	13	43	6	0.3	3.9	0.76	95.5	86.378	62.084
2015	7	8	13	53	6	0.3	3.9	0.78	96.1	86.2467	63.3332
2015	7	8	14	3	6	0.3	3.9	0.72	96.5	86.3123	59.0679
2015	7	8	14	13	6	0.3	3.9	0.74	95.6	86.2467	60.6381
2015	7	8	14	23	6	0.3	3.9	0.77	97.4	86.2467	62.5246
2015	7	8	14	33	6	0.3	3.9	0.78	95.3	86.2467	63.6027
2015	7	8	14	43	6	0.3	3.9	0.78	96.1	86.2467	63.3331
2015	7	8	14	53	6	0.3	3.9	0.79	96	86.3123	64.1925
2015	7	8	15	3	6	0.3	3.9	0.75	95.2	86.2467	61.7161
2015	7	8	15	13	6	0.3	3.9	0.77	94.6	86.1811	63.2828
2015	7	8	15	23	6	0.3	3.9	0.78	97.7	86.1811	63.5521
2015	7	8	15	33	6	0.3	3.9	0.75	97.8	86.2467	60.6381
2015	7	8	15	43	6	0.3	3.9	0.73	95.4	86.2467	59.5601
2015	7	8	15	53	6	0.3	3.9	0.75	95.2	86.2467	61.7161
2015	7	8	16	3	6	0.3	3.9	0.76	94.9	86.1811	62.2057
2015	7	8	16	13	6	0.3	3.9	0.78	98.4	86.2467	63.6026
2015	7	8	16	23	6	0.3	3.9	0.79	98.1	86.2467	64.1416
2015	7	8	16	33	6	0.3	3.9	0.78	96	86.1811	63.5521
2015	7	8	16	43	6	0.3	3.9	0.72	98.2	86.1811	58.1663
2015	7	8	16	53	6	0.3	3.9	0.74	93.6	86.2467	60.6381
2015	7	8	17	3	6	0.3	3.9	0.75	96.6	86.2467	60.9076
2015	7	8	17	13	6	0.3	3.9	0.79	96.9	86.2467	64.1416
2015	7	8	17	23	6	0.3	3.9	0.78	94.8	86.2467	63.8721
2015	7	8	17	33	6	0.3	3.9	0.77	96.1	86.2467	62.7941
2015	7	8	17	43	6	0.3	3.9	0.78	97	86.2467	63.3331
2015	7	8	17	53	6	0.3	3.9	0.77	97.3	86.2467	63.0636
2015	7	8	18	3	6	0.3	3.9	0.79	97.7	86.2467	64.1417
2015	7	8	18	13	6	0.3	3.9	0.76	98.4	86.1811	61.9364
2015	7	8	18	23	6	0.3	3.9	0.78	96	86.2467	63.6027
2015	7	8	18	33	6	0.3	3.9	0.77	96.2	86.2467	62.5247
2015	7	8	18	43	6	0.3	3.9	0.77	96.9	86.2467	62.5247
2015	7	8	18	53	6	0.3	3.9	0.72	98.2	86.1811	58.1664
2015	7	8	19	3	6	0.3	3.9	0.77	99.3	86.1811	62.475
2015	7	8	19	13	6	0.3	3.9	0.78	96.6	86.1811	63.2829
2015	7	8	19	23	6	0.3	3.9	0.8	95.9	86.2467	65.4892
2015	7	8	19	33	6	0.3	3.9	0.79	95.2	86.2467	64.6807
2015	7	8	19	43	6	0.3	3.9	0.83	94.8	86.2467	67.6453
2015	7	8	19	53	6	0.3	3.9	0.81	96.1	86.2467	65.7588

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	8	20	3	6	0.3	3.9	0.79	95.7	86.2467	64.9502
2015	7	8	20	13	6	0.3	3.9	0.82	96.9	86.2467	66.8368
2015	7	8	20	23	6	0.3	3.9	0.78	94.8	86.2467	63.6028
2015	7	8	20	33	6	0.3	3.9	0.83	95.2	86.2467	67.6453
2015	7	8	20	43	6	0.3	3.9	0.79	97.1	86.3123	64.7321
2015	7	8	20	53	6	0.3	3.9	0.8	95.6	86.3123	65.811
2015	7	8	21	3	6	0.3	3.9	0.83	96.1	86.3123	68.2385
2015	7	8	21	13	6	0.3	3.9	0.8	96.4	86.3123	65.0019
2015	7	8	21	23	6	0.3	3.9	0.81	92.1	86.3123	66.8899
2015	7	8	21	33	6	0.3	3.9	0.79	92.9	86.378	64.7835
2015	7	8	21	43	6	0.3	3.9	0.8	95	86.378	65.3234
2015	7	8	21	53	6	0.3	3.9	0.78	97	86.4436	63.4842
2015	7	8	22	3	6	0.3	3.9	0.77	95.4	86.4436	62.9439
2015	7	8	22	13	6	0.3	3.9	0.77	97.3	86.4436	62.9439
2015	7	8	22	23	6	0.3	3.9	0.77	97.4	86.5092	62.7234
2015	7	8	22	33	6	0.3	3.9	0.78	94.6	86.5748	64.3965
2015	7	8	22	43	6	0.3	3.9	0.79	97.2	86.5748	64.6671
2015	7	8	22	53	6	0.3	3.9	0.83	94.3	86.5748	67.914
2015	7	8	23	3	6	0.3	3.9	0.79	95.5	86.5748	64.6672
2015	7	8	23	13	6	0.3	3.9	0.78	94.6	86.5748	64.3966
2015	7	8	23	23	6	0.3	3.9	0.79	96.5	86.5748	64.3966
2015	7	8	23	33	6	0.3	3.9	0.83	94.8	86.5748	68.1846
2015	7	8	23	43	6	0.3	3.9	0.77	97.5	86.6404	63.3644
2015	7	8	23	53	6	0.3	3.9	0.83	96.6	86.6404	67.9678
2015	7	9	0	3	6	0.3	3.9	0.77	95.1	86.6404	63.3644
2015	7	9	0	13	6	0.3	3.9	0.79	93.6	86.6404	64.7184
2015	7	9	0	23	6	0.3	3.9	0.8	97.5	86.6404	65.8015
2015	7	9	0	33	6	0.3	3.9	0.77	96.6	86.706	63.1435
2015	7	9	0	43	6	0.3	3.9	0.77	96.1	86.6404	63.0937
2015	7	9	0	53	6	0.3	3.9	0.79	95.9	86.706	65.0406
2015	7	9	1	3	6	0.3	3.9	0.78	96.1	86.706	63.6856
2015	7	9	1	13	6	0.3	3.9	0.81	96.5	86.706	66.1246
2015	7	9	1	23	6	0.3	3.9	0.81	94.4	86.706	66.6666
2015	7	9	1	33	6	0.3	3.9	0.79	95.7	86.7717	65.3632
2015	7	9	1	43	6	0.3	3.9	0.81	96	86.7717	66.9905
2015	7	9	1	53	6	0.3	3.9	0.77	97.8	86.7717	63.1935
2015	7	9	2	3	6	0.3	3.9	0.81	97.7	86.7717	66.4481
2015	7	9	2	13	6	0.3	3.9	0.77	94.4	86.7717	63.4647
2015	7	9	2	23	6	0.3	3.9	0.79	95	86.7717	64.8208
2015	7	9	2	33	6	0.3	3.9	0.84	96.3	86.7717	68.8891
2015	7	9	2	43	6	0.3	3.9	0.83	97	86.7717	68.3467
2015	7	9	2	53	6	0.3	3.9	0.8	95.9	86.7717	66.1769
2015	7	9	3	3	6	0.3	3.9	0.79	96.2	86.7717	65.0921
2015	7	9	3	13	6	0.3	3.9	0.73	94.1	86.7717	59.939
2015	7	9	3	23	6	0.3	3.9	0.81	94	86.7717	66.7194
2015	7	9	3	33	6	0.3	3.9	0.81	96.8	86.7717	66.4482
2015	7	9	3	43	6	0.3	3.9	0.8	96.4	86.7717	65.3634

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	9	3	53	6	0.3	3.9	0.81	97.7	86.7717	66.4482
2015	7	9	4	3	6	0.3	3.9	0.81	95.6	86.7717	66.4483
2015	7	9	4	13	6	0.3	3.9	0.82	97.2	86.7717	66.9907
2015	7	9	4	23	6	0.3	3.9	0.79	96	86.7717	64.5498
2015	7	9	4	33	6	0.3	3.9	0.81	96.1	86.7717	66.4483
2015	7	9	4	43	6	0.3	3.9	0.83	94.5	86.8373	68.6722
2015	7	9	4	53	6	0.3	3.9	0.74	96.1	86.8373	60.5293
2015	7	9	5	3	6	0.3	3.9	0.8	95.4	86.8373	65.6865
2015	7	9	5	13	6	0.3	3.9	0.78	93.4	86.8373	64.6008
2015	7	9	5	23	6	0.3	3.9	0.78	95.5	86.8373	64.6008
2015	7	9	5	33	6	0.3	3.9	0.77	94.7	86.8373	63.2437
2015	7	9	5	43	6	0.3	3.9	0.79	96.5	86.8373	64.6009
2015	7	9	5	53	6	0.3	3.9	0.81	97	86.8373	66.2295
2015	7	9	6	3	6	0.3	3.9	0.76	97.4	86.8373	62.7009
2015	7	9	6	13	6	0.3	3.9	0.81	97	86.8373	66.7724
2015	7	9	6	23	6	0.3	3.9	0.84	96.5	86.9029	68.7266
2015	7	9	6	33	6	0.3	3.9	0.8	96.8	86.8373	65.9581
2015	7	9	6	43	6	0.3	3.9	0.8	96.8	86.9029	65.7385
2015	7	9	6	53	6	0.3	3.9	0.83	96.6	86.9029	68.1833
2015	7	9	7	3	6	0.3	3.9	0.76	95.4	86.9029	62.7504
2015	7	9	7	13	6	0.3	3.9	0.78	95.8	86.9029	64.6519
2015	7	9	7	23	6	0.3	3.9	0.8	97.7	86.9029	66.0101
2015	7	9	7	33	6	0.3	3.9	0.76	96.4	86.9029	62.4787
2015	7	9	7	43	6	0.3	3.9	0.8	94	86.9685	66.3341
2015	7	9	7	53	6	0.3	3.9	0.78	95.8	86.9685	64.7029
2015	7	9	8	3	6	0.3	3.9	0.81	95.8	86.9685	66.8778
2015	7	9	8	13	6	0.3	3.9	0.79	98.6	86.9685	64.7029
2015	7	9	8	23	6	0.3	3.9	0.8	96.8	87.0341	65.8421
2015	7	9	8	33	6	0.3	3.9	0.81	96.3	87.0341	66.9304
2015	7	9	8	43	6	0.3	3.9	0.81	96.7	87.0997	66.9831
2015	7	9	8	53	6	0.3	3.9	0.76	95.2	87.0997	62.6264
2015	7	9	9	3	6	0.3	3.9	0.74	96.9	87.0997	60.7204
2015	7	9	9	13	6	0.3	3.9	0.78	98.4	87.0997	64.2601
2015	7	9	9	23	6	0.3	3.9	0.81	97.4	87.1654	67.0357
2015	7	9	9	33	6	0.3	3.9	0.79	97.9	87.0997	64.5324
2015	7	9	9	43	6	0.3	3.9	0.79	99.3	87.1654	64.8556
2015	7	9	9	53	6	0.3	3.9	0.81	97.9	87.1654	66.4906
2015	7	9	10	3	6	0.3	3.9	0.81	95.6	87.231	66.8156
2015	7	9	10	13	6	0.3	3.9	0.78	96.5	87.231	64.3611
2015	7	9	10	23	6	0.3	3.9	0.8	97.3	87.231	66.2701
2015	7	9	10	33	6	0.3	3.9	0.79	96.5	87.231	64.9066
2015	7	9	10	43	6	0.3	3.9	0.79	96.9	87.231	65.1793
2015	7	9	10	53	6	0.3	3.9	0.8	96.9	87.231	65.7248
2015	7	9	11	3	6	0.3	3.9	0.78	96.5	87.231	64.6339
2015	7	9	11	13	6	0.3	3.9	0.77	95.6	87.1654	64.0382
2015	7	9	11	23	6	0.3	3.9	0.78	96.5	87.1654	64.5832
2015	7	9	11	33	6	0.3	3.9	0.78	95.8	87.231	64.9066

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	9	11	43	6	0.3	3.9	0.79	96.4	87.231	65.1794
2015	7	9	11	53	6	0.3	3.9	0.78	96.8	87.231	64.0885
2015	7	9	12	3	6	0.3	3.9	0.77	96.9	87.231	63.5431
2015	7	9	12	13	6	0.3	3.9	0.82	95.1	87.2966	67.6869
2015	7	9	12	23	6	0.3	3.9	0.78	95.8	87.2966	64.9576
2015	7	9	12	33	6	0.3	3.9	0.81	95.1	87.2966	67.1411
2015	7	9	12	43	6	0.3	3.9	0.82	96.2	87.3622	68.0132
2015	7	9	12	53	6	0.3	3.9	0.82	96.5	87.3622	67.4669
2015	7	9	13	3	6	0.3	3.9	0.79	97.2	87.3622	65.2817
2015	7	9	13	13	6	0.3	3.9	0.81	96.5	87.3622	66.9206
2015	7	9	13	23	6	0.3	3.9	0.75	97.2	87.3622	62.2771
2015	7	9	13	33	6	0.3	3.9	0.86	95.5	87.4278	71.6202
2015	7	9	13	43	6	0.3	3.9	0.8	95.6	87.4278	66.6997
2015	7	9	13	53	6	0.3	3.9	0.82	96	87.4278	67.7931
2015	7	9	14	3	6	0.3	3.9	0.8	98	87.4278	66.1529
2015	7	9	14	13	6	0.3	3.9	0.8	95.4	87.4278	66.1529
2015	7	9	14	23	6	0.3	3.9	0.78	96.5	87.4278	64.5126
2015	7	9	14	33	6	0.3	3.9	0.79	94.3	87.4934	65.6574
2015	7	9	14	43	6	0.3	3.9	0.8	95	87.4934	66.2046
2015	7	9	14	53	6	0.3	3.9	0.77	93.9	87.4278	63.966
2015	7	9	15	3	6	0.3	3.9	0.8	95.9	87.4934	66.7518
2015	7	9	15	13	6	0.3	3.9	0.8	97.6	87.4278	65.8795
2015	7	9	15	23	6	0.3	3.9	0.82	96.7	87.4934	67.8461
2015	7	9	15	33	6	0.3	3.9	0.8	96.6	87.4934	66.4783
2015	7	9	15	43	6	0.3	3.9	0.81	95.4	87.4934	67.0255
2015	7	9	15	53	6	0.3	3.9	0.82	95.5	87.4934	67.8461
2015	7	9	16	3	6	0.3	3.9	0.81	95.3	87.4934	67.5726
2015	7	9	16	13	6	0.3	3.9	0.79	96.9	87.4934	65.6575
2015	7	9	16	23	6	0.3	3.9	0.82	97.1	87.4934	67.8461
2015	7	9	16	33	6	0.3	3.9	0.76	95.9	87.4934	63.1954
2015	7	9	16	43	6	0.3	3.9	0.79	97.4	87.4934	65.6575
2015	7	9	16	53	6	0.3	3.9	0.82	95.9	87.4934	68.3933
2015	7	9	17	3	6	0.3	3.9	0.82	94.8	87.4934	68.3933
2015	7	9	17	13	6	0.3	3.9	0.78	93.4	87.4934	65.1104
2015	7	9	17	23	6	0.3	3.9	0.81	96.8	87.5591	67.0779
2015	7	9	17	33	6	0.3	3.9	0.78	95.8	87.5591	64.8876
2015	7	9	17	43	6	0.3	3.9	0.81	96	87.5591	67.6255
2015	7	9	17	53	6	0.3	3.9	0.8	94.5	87.5591	66.8041
2015	7	9	18	3	6	0.3	3.9	0.79	95.7	87.5591	65.4352
2015	7	9	18	13	6	0.3	3.9	0.79	95.3	87.5591	65.4352
2015	7	9	18	23	6	0.3	3.9	0.82	93.9	87.5591	67.8993
2015	7	9	18	33	6	0.3	3.9	0.8	96.3	87.5591	66.5303
2015	7	9	18	43	6	0.3	3.9	0.83	97.1	87.6247	68.5004
2015	7	9	18	53	6	0.3	3.9	0.81	97.9	87.6247	66.8564
2015	7	9	19	3	6	0.3	3.9	0.84	97.7	87.6247	69.3224
2015	7	9	19	13	6	0.3	3.9	0.8	97.8	87.6247	66.3084
2015	7	9	19	23	6	0.3	3.9	0.84	97	87.6247	69.3224

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	9	19	33	6	0.3	3.9	0.83	97.7	87.6247	69.0484
2015	7	9	19	43	6	0.3	3.9	0.82	95.5	87.6247	67.9524
2015	7	9	19	53	6	0.3	3.9	0.83	95.4	87.6903	69.1024
2015	7	9	20	3	6	0.3	3.9	0.82	94.6	87.6903	68.2797
2015	7	9	20	13	6	0.3	3.9	0.82	96.2	87.6903	68.2797
2015	7	9	20	23	6	0.3	3.9	0.84	94.9	87.6903	70.1993
2015	7	9	20	33	6	0.3	3.9	0.81	96.5	87.6903	67.1829
2015	7	9	20	43	6	0.3	3.9	0.83	95.2	87.6903	69.1024
2015	7	9	20	53	6	0.3	3.9	0.84	95.4	87.7559	69.9797
2015	7	9	21	3	6	0.3	3.9	0.82	94.6	87.7559	68.3331
2015	7	9	21	13	6	0.3	3.9	0.8	98.7	87.7559	66.4121
2015	7	9	21	23	6	0.3	3.9	0.83	96.1	87.8215	69.2104
2015	7	9	21	33	6	0.3	3.9	0.81	97	87.7559	67.5099
2015	7	9	21	43	6	0.3	3.9	0.81	95.1	87.8871	67.8901
2015	7	9	21	53	6	0.3	3.9	0.79	95.7	87.8871	66.2409
2015	7	9	22	3	6	0.3	3.9	0.81	94.6	87.8871	67.8901
2015	7	9	22	13	6	0.3	3.9	0.79	95.3	87.8871	65.6913
2015	7	9	22	23	6	0.3	3.9	0.85	97.3	87.8871	70.6387
2015	7	9	22	33	6	0.3	3.9	0.8	94.9	87.8871	66.7907
2015	7	9	22	43	6	0.3	3.9	0.8	95.2	87.8871	67.0656
2015	7	9	22	53	6	0.3	3.9	0.84	96.3	87.8871	70.0891
2015	7	9	23	3	6	0.3	3.9	0.77	96.2	87.8871	63.7673
2015	7	9	23	13	6	0.3	3.9	0.86	95.9	87.8871	71.7383
2015	7	9	23	23	6	0.3	3.9	0.79	97.9	87.8871	65.4165
2015	7	9	23	33	6	0.3	3.9	0.82	95.5	87.8871	68.1651
2015	7	9	23	43	6	0.3	3.9	0.82	96.7	87.8215	68.1121
2015	7	9	23	53	6	0.3	3.9	0.83	95.4	87.8215	69.4853
2015	7	10	0	3	6	0.3	3.9	0.83	96.1	87.8215	68.9361
2015	7	10	0	13	6	0.3	3.9	0.83	96.6	87.8215	68.9361
2015	7	10	0	23	6	0.3	3.9	0.81	96.7	87.6903	67.4575
2015	7	10	0	33	6	0.3	3.9	0.83	96.8	87.6903	69.1029
2015	7	10	0	43	6	0.3	3.9	0.8	95.9	87.6247	66.3089
2015	7	10	0	53	6	0.3	3.9	0.8	96.2	87.6247	66.0349
2015	7	10	1	3	6	0.3	3.9	0.76	97.2	87.6247	62.7469
2015	7	10	1	13	6	0.3	3.9	0.81	95.6	87.5591	67.3523
2015	7	10	1	23	6	0.3	3.9	0.84	94.7	87.5591	69.8164
2015	7	10	1	33	6	0.3	3.9	0.78	95.3	87.5591	64.6144
2015	7	10	1	43	6	0.3	3.9	0.8	94.9	87.5591	66.531
2015	7	10	1	53	6	0.3	3.9	0.84	94.5	87.4934	69.4883
2015	7	10	2	3	6	0.3	3.9	0.79	97.4	87.4934	65.3847
2015	7	10	2	13	6	0.3	3.9	0.79	97.4	87.4934	65.3847
2015	7	10	2	23	6	0.3	3.9	0.85	93.1	87.4278	70.8008
2015	7	10	2	33	6	0.3	3.9	0.81	96.5	87.4278	67.2472
2015	7	10	2	43	6	0.3	3.9	0.82	97.8	87.4278	68.0673
2015	7	10	2	53	6	0.3	3.9	0.85	98.2	87.4278	70.2542
2015	7	10	3	3	6	0.3	3.9	0.82	96.7	87.3622	67.7409
2015	7	10	3	13	6	0.3	3.9	0.79	95.3	87.3622	65.2825

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	10	3	23	6	0.3	3.9	0.78	94.6	87.3622	64.7363
2015	7	10	3	33	6	0.3	3.9	0.77	96.3	87.2966	63.8667
2015	7	10	3	43	6	0.3	3.9	0.78	95.8	87.2966	64.9585
2015	7	10	3	53	6	0.3	3.9	0.8	95.4	87.2966	66.5961
2015	7	10	4	3	6	0.3	3.9	0.76	96.5	87.2966	62.5021
2015	7	10	4	13	6	0.3	3.9	0.85	94.2	87.231	70.0893
2015	7	10	4	23	6	0.3	3.9	0.79	97.2	87.231	64.9076
2015	7	10	4	33	6	0.3	3.9	0.81	97	87.231	66.544
2015	7	10	4	43	6	0.3	3.9	0.82	96.2	87.231	67.3622
2015	7	10	4	53	6	0.3	3.9	0.79	96.9	87.231	65.1804
2015	7	10	5	3	6	0.3	3.9	0.78	93.9	87.1654	64.3118
2015	7	10	5	13	6	0.3	3.9	0.81	94.6	87.1654	67.3094
2015	7	10	5	23	6	0.3	3.9	0.78	97	87.1654	64.5843
2015	7	10	5	33	6	0.3	3.9	0.79	96.4	87.0997	65.0782
2015	7	10	5	43	6	0.3	3.9	0.8	93.5	87.0997	66.1674
2015	7	10	5	53	6	0.3	3.9	0.85	96.7	87.0341	69.9245
2015	7	10	6	3	6	0.3	3.9	0.82	95.5	87.0341	68.02
2015	7	10	6	13	6	0.3	3.9	0.78	95.8	87.0341	63.9388
2015	7	10	6	23	6	0.3	3.9	0.76	96.4	86.9685	62.8011
2015	7	10	6	33	6	0.3	3.9	0.79	96.5	86.9685	64.7041
2015	7	10	6	43	6	0.3	3.9	0.81	96.8	86.9029	66.2831
2015	7	10	6	53	6	0.3	3.9	0.8	96.4	86.7717	65.6362
2015	7	10	7	3	6	0.3	3.9	0.81	96.3	86.706	66.3975
2015	7	10	7	13	6	0.3	3.9	0.82	95.3	86.6404	67.1574
2015	7	10	7	23	6	0.3	3.9	0.82	96.5	86.6404	66.8867
2015	7	10	7	33	6	0.3	3.9	0.82	97.1	86.6404	67.4283
2015	7	10	7	43	6	0.3	3.9	0.78	98.5	86.5748	63.5868
2015	7	10	7	53	6	0.3	3.9	0.78	96	86.5748	64.128
2015	7	10	8	3	6	0.3	3.9	0.83	97.5	86.5748	68.1867
2015	7	10	8	13	6	0.3	3.9	0.77	95.9	86.5092	63.2662
2015	7	10	8	23	6	0.3	3.9	0.78	95.5	86.5092	64.3476
2015	7	10	8	33	6	0.3	3.9	0.8	96.1	86.5092	65.4291
2015	7	10	8	43	6	0.3	3.9	0.82	96.9	86.5092	66.7809
2015	7	10	8	53	6	0.3	3.9	0.81	97.7	86.4436	65.9176
2015	7	10	9	3	6	0.3	3.9	0.79	98.1	86.4436	64.5668
2015	7	10	9	13	6	0.3	3.9	0.82	96.7	86.4436	66.9982
2015	7	10	9	23	6	0.3	3.9	0.79	95.2	86.4436	64.8369
2015	7	10	9	33	6	0.3	3.9	0.77	97.4	86.4436	62.6757
2015	7	10	9	43	6	0.3	3.9	0.82	99.2	86.4436	66.9981
2015	7	10	9	53	6	0.3	3.9	0.81	95.8	86.378	66.6751
2015	7	10	10	3	6	0.3	3.9	0.82	95.5	86.378	66.945
2015	7	10	10	13	6	0.3	3.9	0.82	99.2	86.378	66.675
2015	7	10	10	23	6	0.3	3.9	0.8	97.3	86.378	65.0554
2015	7	10	10	33	6	0.3	3.9	0.79	96.4	86.3123	64.734
2015	7	10	10	43	6	0.3	3.9	0.81	95.8	86.3123	66.0826
2015	7	10	10	53	6	0.3	3.9	0.83	98.9	86.3123	67.1615
2015	7	10	11	3	6	0.3	3.9	0.81	98.9	86.2467	65.4911

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	10	11	13	6	0.3	3.9	0.82	98.5	86.2467	66.8387
2015	7	10	11	23	6	0.3	3.9	0.77	95.9	86.1811	62.7461
2015	7	10	11	33	6	0.3	3.9	0.79	95.7	86.0499	64.2596
2015	7	10	11	43	6	0.3	3.9	0.8	96.1	85.9843	65.283
2015	7	10	11	53	6	0.3	3.9	0.75	96.5	85.9186	61.2044
2015	7	10	12	3	6	0.3	3.9	0.8	96.9	85.9186	64.6941
2015	7	10	12	13	6	0.3	3.9	0.75	98.8	85.9186	60.9359
2015	7	10	12	23	6	0.3	3.9	0.79	96.4	85.9186	64.4256
2015	7	10	12	33	6	0.3	3.9	0.78	95.5	85.853	63.8377
2015	7	10	12	43	6	0.3	3.9	0.77	94.9	85.853	62.7648
2015	7	10	12	53	6	0.3	3.9	0.82	94.1	85.853	67.0564
2015	7	10	13	3	6	0.3	3.9	0.79	96.4	85.853	64.1058
2015	7	10	13	13	6	0.3	3.9	0.76	95.7	85.7874	61.9107
2015	7	10	13	23	6	0.3	3.9	0.76	96.7	85.7874	61.6425
2015	7	10	13	33	6	0.3	3.9	0.8	98.1	85.7874	64.3227
2015	7	10	13	43	6	0.3	3.9	0.74	95.6	85.7874	60.5706
2015	7	10	13	53	6	0.3	3.9	0.76	96.7	85.7218	61.5934
2015	7	10	14	3	6	0.3	3.9	0.8	96.6	85.7218	64.5392
2015	7	10	14	13	6	0.3	3.9	0.76	98.5	85.7218	61.0578
2015	7	10	14	23	6	0.3	3.9	0.77	96.4	85.7218	62.3968
2015	7	10	14	33	6	0.3	3.9	0.74	93.8	85.7218	60.2544
2015	7	10	14	43	6	0.3	3.9	0.78	97.2	85.7218	63.468
2015	7	10	14	53	6	0.3	3.9	0.72	99.5	85.7218	57.5764
2015	7	10	15	3	6	0.3	3.9	0.73	97.8	85.6562	58.8683
2015	7	10	15	13	6	0.3	3.9	0.71	95.8	85.6562	57.798
2015	7	10	15	23	6	0.3	3.9	0.76	97.2	85.6562	61.8117
2015	7	10	15	33	6	0.3	3.9	0.77	98.4	85.6562	61.8117
2015	7	10	15	43	6	0.3	3.9	0.78	98.5	85.6562	62.882
2015	7	10	15	53	6	0.3	3.9	0.82	96.7	85.6562	66.3606
2015	7	10	16	3	6	0.3	3.9	0.77	97.1	85.6562	62.3469
2015	7	10	16	13	6	0.3	3.9	0.79	94.5	85.6562	64.4875
2015	7	10	16	23	6	0.3	3.9	0.79	96	85.6562	63.9524
2015	7	10	16	33	6	0.3	3.9	0.75	96.3	85.6562	60.4738
2015	7	10	16	43	6	0.3	3.9	0.76	97.2	85.6562	61.8117
2015	7	10	16	53	6	0.3	3.9	0.81	95.8	85.5906	65.5054
2015	7	10	17	3	6	0.3	3.9	0.8	97.3	85.6562	65.0227
2015	7	10	17	13	6	0.3	3.9	0.81	96.5	85.5906	65.5054
2015	7	10	17	23	6	0.3	3.9	0.8	95.4	85.5906	64.9707
2015	7	10	17	33	6	0.3	3.9	0.78	96.1	85.5906	62.8318
2015	7	10	17	43	6	0.3	3.9	0.8	95.7	85.5906	64.7034
2015	7	10	17	53	6	0.3	3.9	0.76	96.4	85.5906	61.7623
2015	7	10	18	3	6	0.3	3.9	0.76	96.2	85.5906	61.7623
2015	7	10	18	13	6	0.3	3.9	0.74	96.4	85.5906	59.8907
2015	7	10	18	23	6	0.3	3.9	0.81	93.7	85.5906	65.7728
2015	7	10	18	33	6	0.3	3.9	0.81	95.6	85.5906	65.5055
2015	7	10	18	43	6	0.3	3.9	0.78	94.1	85.5906	63.0992
2015	7	10	18	53	6	0.3	3.9	0.8	96.9	85.5906	64.436

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	10	19	3	6	0.3	3.9	0.77	94.6	85.5906	62.5644
2015	7	10	19	13	6	0.3	3.9	0.77	96.1	85.5906	62.5644
2015	7	10	19	23	6	0.3	3.9	0.78	96	85.5906	63.3666
2015	7	10	19	33	6	0.3	3.9	0.8	96.8	85.5906	64.9708
2015	7	10	19	43	6	0.3	3.9	0.78	95.8	85.5906	63.6339
2015	7	10	19	53	6	0.3	3.9	0.79	96.4	85.5906	63.9013
2015	7	10	20	3	6	0.3	3.9	0.77	97.1	85.6562	62.6145
2015	7	10	20	13	6	0.3	3.9	0.78	95.8	85.6562	63.4173
2015	7	10	20	23	6	0.3	3.9	0.79	95	85.6562	64.22
2015	7	10	20	33	6	0.3	3.9	0.83	97.5	85.6562	67.431
2015	7	10	20	43	6	0.3	3.9	0.8	95.2	85.6562	65.2904
2015	7	10	20	53	6	0.3	3.9	0.8	96.6	85.6562	64.4876
2015	7	10	21	3	6	0.3	3.9	0.8	95.4	85.6562	65.0228
2015	7	10	21	13	6	0.3	3.9	0.77	98.8	85.6562	62.347
2015	7	10	21	23	6	0.3	3.9	0.77	95.6	85.7218	62.9324
2015	7	10	21	33	6	0.3	3.9	0.74	95.9	85.6562	59.6712
2015	7	10	21	43	6	0.3	3.9	0.8	98	85.7218	64.807
2015	7	10	21	53	6	0.3	3.9	0.82	98.7	85.7218	66.4138
2015	7	10	22	3	6	0.3	3.9	0.81	98.4	85.7218	65.6105
2015	7	10	22	13	6	0.3	3.9	0.8	96.6	85.7218	64.5393
2015	7	10	22	23	6	0.3	3.9	0.75	99.8	85.7218	60.5223
2015	7	10	22	33	6	0.3	3.9	0.79	97.1	85.7218	64.2715
2015	7	10	22	43	6	0.3	3.9	0.8	98	85.7218	64.8071
2015	7	10	22	53	6	0.3	3.9	0.82	95.3	85.7218	66.9495
2015	7	10	23	3	6	0.3	3.9	0.74	96.4	85.7218	59.719
2015	7	10	23	13	6	0.3	3.9	0.76	96.2	85.7218	61.8614
2015	7	10	23	23	6	0.3	3.9	0.84	96.3	85.7874	68.0751
2015	7	10	23	33	6	0.3	3.9	0.86	97	85.7218	69.3597
2015	7	10	23	43	6	0.3	3.9	0.8	97.3	85.7874	64.5909
2015	7	10	23	53	6	0.3	3.9	0.77	95.6	85.7874	62.9829
2015	7	11	0	3	6	0.3	3.9	0.8	97.3	85.7874	65.127
2015	7	11	0	13	6	0.3	3.9	0.76	95.2	85.7874	61.9109
2015	7	11	0	23	6	0.3	3.9	0.76	96.4	85.7874	61.6429
2015	7	11	0	33	6	0.3	3.9	0.8	98.2	85.7874	64.859
2015	7	11	0	43	6	0.3	3.9	0.83	95.7	85.7874	67.5392
2015	7	11	0	53	6	0.3	3.9	0.77	97.6	85.7874	62.4469
2015	7	11	1	3	6	0.3	3.9	0.8	94.5	85.7874	64.8591
2015	7	11	1	13	6	0.3	3.9	0.8	95.6	85.853	65.1791
2015	7	11	1	23	6	0.3	3.9	0.79	95.2	85.853	64.3744
2015	7	11	1	33	6	0.3	3.9	0.85	98.4	85.853	68.6661
2015	7	11	1	43	6	0.3	3.9	0.78	98	85.853	63.3015
2015	7	11	1	53	6	0.3	3.9	0.76	95.2	85.853	61.9604
2015	7	11	2	3	6	0.3	3.9	0.81	95.8	85.853	65.7156
2015	7	11	2	13	6	0.3	3.9	0.77	97.1	85.9186	62.8152
2015	7	11	2	23	6	0.3	3.9	0.8	98	85.9186	64.9627
2015	7	11	2	33	6	0.3	3.9	0.82	95.5	85.9186	66.8419
2015	7	11	2	43	6	0.3	3.9	0.83	98.7	85.9186	66.8419

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	11	2	53	6	0.3	3.9	0.79	98.4	85.9186	63.6206
2015	7	11	3	3	6	0.3	3.9	0.82	96	85.9186	66.5735
2015	7	11	3	13	6	0.3	3.9	0.79	96.9	85.9843	63.94
2015	7	11	3	23	6	0.3	3.9	0.84	96.7	85.9843	68.5072
2015	7	11	3	33	6	0.3	3.9	0.76	95.9	86.1155	62.1583
2015	7	11	3	43	6	0.3	3.9	0.83	97.5	86.1811	67.5937
2015	7	11	3	53	6	0.3	3.9	0.79	98.4	86.1811	63.8236
2015	7	11	4	3	6	0.3	3.9	0.81	97	86.1811	65.978
2015	7	11	4	13	6	0.3	3.9	0.79	96.2	86.2467	64.1438
2015	7	11	4	23	6	0.3	3.9	0.79	98.8	86.2467	64.1438
2015	7	11	4	33	6	0.3	3.9	0.8	96.4	86.2467	65.2219
2015	7	11	4	43	6	0.3	3.9	0.8	95.6	86.2467	65.7609
2015	7	11	4	53	6	0.3	3.9	0.81	96.8	86.2467	65.761
2015	7	11	5	3	6	0.3	3.9	0.83	96.6	86.2467	67.6476
2015	7	11	5	13	6	0.3	3.9	0.79	97.1	86.3123	64.7343
2015	7	11	5	23	6	0.3	3.9	0.83	96.8	86.3123	67.9711
2015	7	11	5	33	6	0.3	3.9	0.78	98	86.3123	63.6555
2015	7	11	5	43	6	0.3	3.9	0.82	97.4	86.3123	66.8922
2015	7	11	5	53	6	0.3	3.9	0.81	97.7	86.3123	65.8133
2015	7	11	6	3	6	0.3	3.9	0.83	98.6	86.3123	67.4317
2015	7	11	6	13	6	0.3	3.9	0.77	95.9	86.3123	62.5766
2015	7	11	6	23	6	0.3	3.9	0.83	96.3	86.3123	67.9712
2015	7	11	6	33	6	0.3	3.9	0.81	96.5	86.378	66.4055
2015	7	11	6	43	6	0.3	3.9	0.81	96.1	86.378	65.8656
2015	7	11	6	53	6	0.3	3.9	0.82	96.4	86.3123	67.1621
2015	7	11	7	3	6	0.3	3.9	0.78	96.6	86.378	63.4362
2015	7	11	7	13	6	0.3	3.9	0.83	98.2	86.378	67.2154
2015	7	11	7	23	6	0.3	3.9	0.8	95.6	86.378	65.5958
2015	7	11	7	33	6	0.3	3.9	0.79	97.6	86.378	64.7859
2015	7	11	7	43	6	0.3	3.9	0.78	97.8	86.378	63.4362
2015	7	11	7	53	6	0.3	3.9	0.77	97.4	86.378	62.6264
2015	7	11	8	3	6	0.3	3.9	0.79	96.9	86.378	64.2461
2015	7	11	8	13	6	0.3	3.9	0.81	97.9	86.378	66.4056
2015	7	11	8	23	6	0.3	3.9	0.77	97.4	86.378	62.6264
2015	7	11	8	33	6	0.3	3.9	0.83	95.5	86.378	67.7553
2015	7	11	8	43	6	0.3	3.9	0.81	96.8	86.4436	65.9179
2015	7	11	8	53	6	0.3	3.9	0.81	96.1	86.4436	65.9179
2015	7	11	9	3	6	0.3	3.9	0.84	98.8	86.4436	68.0791
2015	7	11	9	13	6	0.3	3.9	0.82	96.5	86.4436	66.7283
2015	7	11	9	23	6	0.3	3.9	0.8	97.8	86.4436	65.3776
2015	7	11	9	33	6	0.3	3.9	0.8	95.6	86.4436	65.9178
2015	7	11	9	43	6	0.3	3.9	0.8	96.4	86.4436	65.3775
2015	7	11	9	53	6	0.3	3.9	0.81	96.3	86.5092	66.2404
2015	7	11	10	3	6	0.3	3.9	0.83	96.4	86.5092	67.5922
2015	7	11	10	13	6	0.3	3.9	0.79	96.4	86.5092	64.8885
2015	7	11	10	23	6	0.3	3.9	0.78	97.7	86.5092	64.0774
2015	7	11	10	33	6	0.3	3.9	0.82	96.5	86.5092	66.781

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	11	10	43	6	0.3	3.9	0.78	95.8	86.5092	64.0773
2015	7	11	10	53	6	0.3	3.9	0.81	98.4	86.5092	65.9698
2015	7	11	11	3	6	0.3	3.9	0.74	99.4	86.5092	60.2921
2015	7	11	11	13	6	0.3	3.9	0.8	97.1	86.5092	65.4291
2015	7	11	11	23	6	0.3	3.9	0.77	95.9	86.5092	62.9957
2015	7	11	11	33	6	0.3	3.9	0.74	98.4	86.5748	60.3397
2015	7	11	11	43	6	0.3	3.9	0.77	96.2	86.5748	62.7749
2015	7	11	11	53	6	0.3	3.9	0.75	98.3	86.5748	61.1514
2015	7	11	12	3	6	0.3	3.9	0.77	98.3	86.5748	63.0455
2015	7	11	12	13	6	0.3	3.9	0.76	96.2	86.5748	61.9631
2015	7	11	12	23	6	0.3	3.9	0.8	96.6	86.5748	65.7512
2015	7	11	12	33	6	0.3	3.9	0.76	97	86.5748	61.963
2015	7	11	12	43	6	0.3	3.9	0.82	96.4	86.5748	67.104
2015	7	11	12	53	6	0.3	3.9	0.79	96.7	86.5748	64.3982
2015	7	11	13	3	6	0.3	3.9	0.77	96.6	86.5748	62.7747
2015	7	11	13	13	6	0.3	3.9	0.76	95.2	86.5748	62.5041
2015	7	11	13	23	6	0.3	3.9	0.81	98.8	86.5748	66.2922
2015	7	11	13	33	6	0.3	3.9	0.79	98.1	86.5748	64.3981
2015	7	11	13	43	6	0.3	3.9	0.75	98.1	86.5748	60.8805
2015	7	11	13	53	6	0.3	3.9	0.82	95.5	86.5748	67.1038
2015	7	11	14	3	6	0.3	3.9	0.77	95.9	86.5748	63.3157
2015	7	11	14	13	6	0.3	3.9	0.78	99.5	86.5748	63.3157
2015	7	11	14	23	6	0.3	3.9	0.79	96.9	86.5748	64.6686
2015	7	11	14	33	6	0.3	3.9	0.78	97.5	86.5748	63.8568
2015	7	11	14	43	6	0.3	3.9	0.79	95.7	86.5748	64.9391
2015	7	11	14	53	6	0.3	3.9	0.77	94.4	86.5748	63.0451
2015	7	11	15	3	6	0.3	3.9	0.78	96.8	86.5748	63.8568
2015	7	11	15	13	6	0.3	3.9	0.82	97.4	86.5748	66.8332
2015	7	11	15	23	6	0.3	3.9	0.84	97	86.5092	68.4025
2015	7	11	15	33	6	0.3	3.9	0.76	97.9	86.5748	62.2333
2015	7	11	15	43	6	0.3	3.9	0.77	95.9	86.5748	62.7744
2015	7	11	15	53	6	0.3	3.9	0.76	95.5	86.5748	62.2332
2015	7	11	16	3	6	0.3	3.9	0.76	97.6	86.5748	62.5038
2015	7	11	16	13	6	0.3	3.9	0.78	96.8	86.5748	63.5861
2015	7	11	16	23	6	0.3	3.9	0.75	95.5	86.5092	61.9136
2015	7	11	16	33	6	0.3	3.9	0.78	95.8	86.5748	63.8567
2015	7	11	16	43	6	0.3	3.9	0.76	94.7	86.5748	62.5038
2015	7	11	16	53	6	0.3	3.9	0.76	98.9	86.5092	62.184
2015	7	11	17	3	6	0.3	3.9	0.77	95.4	86.5748	63.3155
2015	7	11	17	13	6	0.3	3.9	0.8	97.3	86.5748	65.7507
2015	7	11	17	23	6	0.3	3.9	0.78	99.4	86.5748	63.5861
2015	7	11	17	33	6	0.3	3.9	0.71	96.6	86.6404	58.4913
2015	7	11	17	43	6	0.3	3.9	0.77	98.6	86.6404	62.824
2015	7	11	17	53	6	0.3	3.9	0.8	97.7	86.5748	65.7508
2015	7	11	18	3	6	0.3	3.9	0.75	98.6	86.6404	60.9285
2015	7	11	18	13	6	0.3	3.9	0.77	96.6	86.6404	63.3656
2015	7	11	18	23	6	0.3	3.9	0.76	98.4	86.6404	62.2825

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	11	18	33	6	0.3	3.9	0.75	96	86.6404	61.4701
2015	7	11	18	43	6	0.3	3.9	0.73	98	86.6404	59.8453
2015	7	11	18	53	6	0.3	3.9	0.75	96.8	86.706	61.2477
2015	7	11	19	3	6	0.3	3.9	0.77	96.9	86.6404	63.0948
2015	7	11	19	13	6	0.3	3.9	0.74	96.3	86.706	60.9767
2015	7	11	19	23	6	0.3	3.9	0.77	97.8	86.706	63.4157
2015	7	11	19	33	6	0.3	3.9	0.75	97.6	86.706	61.2477
2015	7	11	19	43	6	0.3	3.9	0.74	99.2	86.706	60.4347
2015	7	11	19	53	6	0.3	3.9	0.75	97.1	86.7717	61.296
2015	7	11	20	3	6	0.3	3.9	0.78	94.8	86.7717	64.0083
2015	7	11	20	13	6	0.3	3.9	0.79	97.4	86.7717	65.0931
2015	7	11	20	23	6	0.3	3.9	0.75	97.6	86.8373	61.3444
2015	7	11	20	33	6	0.3	3.9	0.77	96.6	86.8373	63.5159
2015	7	11	20	43	6	0.3	3.9	0.75	99.8	86.9685	61.1693
2015	7	11	20	53	6	0.3	3.9	0.8	97.8	86.9685	65.5191
2015	7	11	21	3	6	0.3	3.9	0.76	98.2	87.0341	62.5779
2015	7	11	21	13	6	0.3	3.9	0.76	98.4	87.0997	62.6271
2015	7	11	21	23	6	0.3	3.9	0.75	95.5	87.0341	61.7616
2015	7	11	21	33	6	0.3	3.9	0.78	100.1	87.1654	64.0389
2015	7	11	21	43	6	0.3	3.9	0.8	94.5	87.1654	65.9464
2015	7	11	21	53	6	0.3	3.9	0.77	98.4	87.1654	62.9489
2015	7	11	22	3	6	0.3	3.9	0.75	96.3	87.231	61.9074
2015	7	11	22	13	6	0.3	3.9	0.74	95.8	87.231	61.362
2015	7	11	22	23	6	0.3	3.9	0.78	98.7	87.231	64.0892
2015	7	11	22	33	6	0.3	3.9	0.78	94.6	87.2966	64.6854
2015	7	11	22	43	6	0.3	3.9	0.76	96.2	87.2966	63.0478
2015	7	11	22	53	6	0.3	3.9	0.76	93.7	87.2966	63.0478
2015	7	11	23	3	6	0.3	3.9	0.81	95.8	87.2966	66.8689
2015	7	11	23	13	6	0.3	3.9	0.77	97.3	87.2966	63.8666
2015	7	11	23	23	6	0.3	3.9	0.8	97.3	87.2966	65.7771
2015	7	11	23	33	6	0.3	3.9	0.76	97.6	87.3622	63.0973
2015	7	11	23	43	6	0.3	3.9	0.74	95.1	87.3622	61.7315
2015	7	11	23	53	6	0.3	3.9	0.78	96.1	87.3622	64.1898
2015	7	12	0	3	6	0.3	3.9	0.79	95.5	87.3622	65.8288
2015	7	12	0	13	6	0.3	3.9	0.81	97.9	87.4278	66.9738
2015	7	12	0	23	6	0.3	3.9	0.8	97.3	87.4278	66.4271
2015	7	12	0	33	6	0.3	3.9	0.76	96.7	87.4278	62.8734
2015	7	12	0	43	6	0.3	3.9	0.77	95.6	87.4278	64.2402
2015	7	12	0	53	6	0.3	3.9	0.8	98	87.4934	65.932
2015	7	12	1	3	6	0.3	3.9	0.82	98.3	87.4934	67.2999
2015	7	12	1	13	6	0.3	3.9	0.75	95	87.4934	62.1019
2015	7	12	1	23	6	0.3	3.9	0.79	95.5	87.5591	65.7098
2015	7	12	1	33	6	0.3	3.9	0.83	96.4	87.5591	68.7215
2015	7	12	1	43	6	0.3	3.9	0.79	96.7	87.6903	65.8125
2015	7	12	1	53	6	0.3	3.9	0.81	94.7	87.7559	67.2361
2015	7	12	2	3	6	0.3	3.9	0.84	95.6	87.8215	70.035
2015	7	12	2	13	6	0.3	3.9	0.8	94.7	87.8215	67.0139

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	12	2	23	6	0.3	3.9	0.81	97.9	87.8871	67.341
2015	7	12	2	33	6	0.3	3.9	0.82	96.9	87.8871	68.4405
2015	7	12	2	43	6	0.3	3.9	0.85	97.1	87.8871	70.6394
2015	7	12	2	53	6	0.3	3.9	0.83	97.5	87.9528	69.319
2015	7	12	3	3	6	0.3	3.9	0.79	95.7	87.9528	65.7431
2015	7	12	3	13	6	0.3	3.9	0.79	95.5	87.9528	66.0182
2015	7	12	3	23	6	0.3	3.9	0.83	97.5	88.0184	69.373
2015	7	12	3	33	6	0.3	3.9	0.85	97.3	88.0184	70.7495
2015	7	12	3	43	6	0.3	3.9	0.86	97.3	88.0184	71.3001
2015	7	12	3	53	6	0.3	3.9	0.76	95.7	88.0184	63.0414
2015	7	12	4	3	6	0.3	3.9	0.85	96.7	88.0184	70.7495
2015	7	12	4	13	6	0.3	3.9	0.81	94	88.0184	67.4461
2015	7	12	4	23	6	0.3	3.9	0.8	95.6	88.0184	67.1708
2015	7	12	4	33	6	0.3	3.9	0.79	96.2	88.084	65.8455
2015	7	12	4	43	6	0.3	3.9	0.84	95.6	88.084	69.9781
2015	7	12	4	53	6	0.3	3.9	0.79	97.9	88.084	65.8456
2015	7	12	5	3	6	0.3	3.9	0.81	95.1	88.084	67.4986
2015	7	12	5	13	6	0.3	3.9	0.84	96.3	88.084	69.7027
2015	7	12	5	23	6	0.3	3.9	0.79	94.3	88.084	66.3966
2015	7	12	5	33	6	0.3	3.9	0.82	96.4	88.084	68.6007
2015	7	12	5	43	6	0.3	3.9	0.82	96.2	88.1496	68.654
2015	7	12	5	53	6	0.3	3.9	0.82	95.5	88.1496	68.3783
2015	7	12	6	3	6	0.3	3.9	0.84	95.2	88.1496	70.0326
2015	7	12	6	13	6	0.3	3.9	0.8	94.2	88.1496	66.9998
2015	7	12	6	23	6	0.3	3.9	0.84	94.7	88.1496	70.0327
2015	7	12	6	33	6	0.3	3.9	0.8	94.9	88.1496	66.9998
2015	7	12	6	43	6	0.3	3.9	0.79	96.7	88.2152	66.224
2015	7	12	6	53	6	0.3	3.9	0.79	95.7	88.2152	66.5
2015	7	12	7	3	6	0.3	3.9	0.83	99.4	88.2152	68.7075
2015	7	12	7	13	6	0.3	3.9	0.8	95.9	88.2152	66.776
2015	7	12	7	23	6	0.3	3.9	0.82	96.2	88.2808	69.037
2015	7	12	7	33	6	0.3	3.9	0.77	95.1	88.3465	64.6687
2015	7	12	7	43	6	0.3	3.9	0.82	95.1	88.4121	68.5909
2015	7	12	7	53	6	0.3	3.9	0.82	95.7	88.4777	69.1976
2015	7	12	8	3	6	0.3	3.9	0.8	98	88.4777	66.7065
2015	7	12	8	13	6	0.3	3.9	0.82	97.6	88.5433	68.6971
2015	7	12	8	23	6	0.3	3.9	0.78	97	88.5433	65.6501
2015	7	12	8	33	6	0.3	3.9	0.84	96.3	88.5433	70.3591
2015	7	12	8	43	6	0.3	3.9	0.85	95.1	88.5433	71.1901
2015	7	12	8	53	6	0.3	3.9	0.81	96.1	88.5433	67.5891
2015	7	12	9	3	6	0.3	3.9	0.84	97.6	88.5433	70.3591
2015	7	12	9	13	6	0.3	3.9	0.79	95	88.6089	66.8096
2015	7	12	9	23	6	0.3	3.9	0.8	96.4	88.6089	67.0869
2015	7	12	9	33	6	0.3	3.9	0.79	96.9	88.6089	65.978
2015	7	12	9	43	6	0.3	3.9	0.84	96.2	88.6089	70.9679
2015	7	12	9	53	6	0.3	3.9	0.83	97.3	88.6089	69.3045
2015	7	12	10	3	6	0.3	3.9	0.8	96.2	88.6089	66.8096

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	12	10	13	6	0.3	3.9	0.84	98.5	88.6089	70.1362
2015	7	12	10	23	6	0.3	3.9	0.77	96.3	88.6089	64.869
2015	7	12	10	33	6	0.3	3.9	0.8	96.3	88.6745	67.416
2015	7	12	10	43	6	0.3	3.9	0.82	96.4	88.6089	69.0272
2015	7	12	10	53	6	0.3	3.9	0.82	96.4	88.6089	68.75
2015	7	12	11	3	6	0.3	3.9	0.75	97.2	88.6089	63.2056
2015	7	12	11	13	6	0.3	3.9	0.81	97	88.6089	67.9183
2015	7	12	11	23	6	0.3	3.9	0.77	97.1	88.6089	64.8688
2015	7	12	11	33	6	0.3	3.9	0.77	96.4	88.6089	64.5916
2015	7	12	11	43	6	0.3	3.9	0.79	96.7	88.6089	66.5321
2015	7	12	11	53	6	0.3	3.9	0.76	97.9	88.6745	63.8091
2015	7	12	12	3	6	0.3	3.9	0.81	97.2	88.6745	67.6932
2015	7	12	12	13	6	0.3	3.9	0.82	96.5	88.6745	68.5255
2015	7	12	12	23	6	0.3	3.9	0.81	97.4	88.6745	67.9705
2015	7	12	12	33	6	0.3	3.9	0.76	96.2	88.6089	63.4826
2015	7	12	12	43	6	0.3	3.9	0.77	95.4	88.6089	64.8686
2015	7	12	12	53	6	0.3	3.9	0.78	97.3	88.6089	65.1458
2015	7	12	13	3	6	0.3	3.9	0.76	97.2	88.6089	63.4825
2015	7	12	13	13	6	0.3	3.9	0.79	96.9	88.6089	66.2546
2015	7	12	13	23	6	0.3	3.9	0.84	96.1	88.6089	70.4128
2015	7	12	13	33	6	0.3	3.9	0.76	98.2	88.6089	63.7596
2015	7	12	13	43	6	0.3	3.9	0.8	98	88.6089	67.0862
2015	7	12	13	53	6	0.3	3.9	0.77	97.8	88.5433	64.8183
2015	7	12	14	3	6	0.3	3.9	0.8	98.1	88.5433	66.4803
2015	7	12	14	13	6	0.3	3.9	0.81	98.6	88.5433	67.5883
2015	7	12	14	23	6	0.3	3.9	0.81	95.8	88.5433	68.1423
2015	7	12	14	33	6	0.3	3.9	0.77	96.1	88.5433	64.5412
2015	7	12	14	43	6	0.3	3.9	0.77	98.9	88.5433	63.9872
2015	7	12	14	53	6	0.3	3.9	0.84	96	88.5433	70.9122
2015	7	12	15	3	6	0.3	3.9	0.81	98.6	88.4777	67.5359
2015	7	12	15	13	6	0.3	3.9	0.83	95.7	88.5433	69.5271
2015	7	12	15	23	6	0.3	3.9	0.8	96.6	88.5433	67.3111
2015	7	12	15	33	6	0.3	3.9	0.8	96.8	88.5433	67.0341
2015	7	12	15	43	6	0.3	3.9	0.75	96.5	88.5433	63.1561
2015	7	12	15	53	6	0.3	3.9	0.8	98.7	88.4777	66.9823
2015	7	12	16	3	6	0.3	3.9	0.75	97	88.4777	62.8305
2015	7	12	16	13	6	0.3	3.9	0.79	97.4	88.4777	65.8751
2015	7	12	16	23	6	0.3	3.9	0.79	97.4	88.4777	66.4287
2015	7	12	16	33	6	0.3	3.9	0.74	97.6	88.4777	62.2769
2015	7	12	16	43	6	0.3	3.9	0.8	96.6	88.4777	66.9822
2015	7	12	16	53	6	0.3	3.9	0.78	96.5	88.4777	65.3215
2015	7	12	17	3	6	0.3	3.9	0.75	95.5	88.4777	63.384
2015	7	12	17	13	6	0.3	3.9	0.79	94.5	88.5433	66.203
2015	7	12	17	23	6	0.3	3.9	0.75	97.3	88.4777	62.5536
2015	7	12	17	33	6	0.3	3.9	0.75	96.8	88.4777	62.8304
2015	7	12	17	43	6	0.3	3.9	0.77	98.6	88.4121	63.8881
2015	7	12	17	53	6	0.3	3.9	0.78	97.2	88.4777	65.3215

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	12	18	3	6	0.3	3.9	0.76	96.2	88.4777	63.384
2015	7	12	18	13	6	0.3	3.9	0.79	95.3	88.4777	66.1519
2015	7	12	18	23	6	0.3	3.9	0.77	97.1	88.4777	64.7679
2015	7	12	18	33	6	0.3	3.9	0.75	97.7	88.4777	63.1072
2015	7	12	18	43	6	0.3	3.9	0.77	96.6	88.4777	64.2144
2015	7	12	18	53	6	0.3	3.9	0.77	97.8	88.4777	64.768
2015	7	12	19	3	6	0.3	3.9	0.8	96.6	88.4777	67.259
2015	7	12	19	13	6	0.3	3.9	0.78	97.5	88.4777	65.3215
2015	7	12	19	23	6	0.3	3.9	0.82	96.5	88.5433	68.4191
2015	7	12	19	33	6	0.3	3.9	0.77	95.4	88.4777	64.768
2015	7	12	19	43	6	0.3	3.9	0.79	97.2	88.4777	66.1519
2015	7	12	19	53	6	0.3	3.9	0.76	98.4	88.4777	63.6608
2015	7	12	20	3	6	0.3	3.9	0.81	98.4	88.4777	67.259
2015	7	12	20	13	6	0.3	3.9	0.75	95	88.5433	62.8791
2015	7	12	20	23	6	0.3	3.9	0.78	96.8	88.6089	65.4226
2015	7	12	20	33	6	0.3	3.9	0.78	97.7	88.6089	65.6998
2015	7	12	20	43	6	0.3	3.9	0.79	97.4	88.6089	66.5315
2015	7	12	20	53	6	0.3	3.9	0.75	97.5	88.6089	62.9277
2015	7	12	21	3	6	0.3	3.9	0.77	97.4	88.6745	64.3634
2015	7	12	21	13	6	0.3	3.9	0.78	95.8	88.6745	65.7506
2015	7	12	21	23	6	0.3	3.9	0.78	95	88.6745	66.028
2015	7	12	21	33	6	0.3	3.9	0.77	96.2	88.6745	64.3634
2015	7	12	21	43	6	0.3	3.9	0.79	96.9	88.7402	66.079
2015	7	12	21	53	6	0.3	3.9	0.82	97.4	88.7402	68.5778
2015	7	12	22	3	6	0.3	3.9	0.79	95.9	88.7402	66.9119
2015	7	12	22	13	6	0.3	3.9	0.77	96.2	88.7402	64.4132
2015	7	12	22	23	6	0.3	3.9	0.8	95.7	88.7402	67.1896
2015	7	12	22	33	6	0.3	3.9	0.78	96.8	88.8058	65.2964
2015	7	12	22	43	6	0.3	3.9	0.8	98.7	88.8058	66.9636
2015	7	12	22	53	6	0.3	3.9	0.75	96.5	88.8058	63.3514
2015	7	12	23	3	6	0.3	3.9	0.76	96.9	88.8058	63.9072
2015	7	12	23	13	6	0.3	3.9	0.81	99	88.8058	68.075
2015	7	12	23	23	6	0.3	3.9	0.77	96.4	88.8058	64.7407
2015	7	12	23	33	6	0.3	3.9	0.76	97.2	88.8058	64.185
2015	7	12	23	43	6	0.3	3.9	0.78	96.5	88.8058	65.8522
2015	7	12	23	53	6	0.3	3.9	0.79	98.4	88.8058	65.8522
2015	7	13	0	3	6	0.3	3.9	0.78	98	88.8058	65.5744
2015	7	13	0	13	6	0.3	3.9	0.74	96.3	88.8058	62.5179
2015	7	13	0	23	6	0.3	3.9	0.81	97	88.8714	68.4056
2015	7	13	0	33	6	0.3	3.9	0.78	98.2	88.8714	65.3468
2015	7	13	0	43	6	0.3	3.9	0.78	95.8	88.8714	65.6249
2015	7	13	0	53	6	0.3	3.9	0.79	96.7	88.8714	66.7372
2015	7	13	1	3	6	0.3	3.9	0.75	97.5	88.8714	63.1223
2015	7	13	1	13	6	0.3	3.9	0.78	94.6	88.8714	65.625
2015	7	13	1	23	6	0.3	3.9	0.76	96.2	88.8714	64.2346
2015	7	13	1	33	6	0.3	3.9	0.77	98.1	88.8714	64.2346
2015	7	13	1	43	6	0.3	3.9	0.86	95.7	88.8714	72.5768

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	13	1	53	6	0.3	3.9	0.83	95	88.8714	69.7961
2015	7	13	2	3	6	0.3	3.9	0.84	96.5	88.8714	70.9083
2015	7	13	2	13	6	0.3	3.9	0.83	97.5	88.937	70.1281
2015	7	13	2	23	6	0.3	3.9	0.83	96.1	88.937	70.1281
2015	7	13	2	33	6	0.3	3.9	0.81	95.6	88.8714	68.4057
2015	7	13	2	43	6	0.3	3.9	0.83	98.5	88.8714	69.24
2015	7	13	2	53	6	0.3	3.9	0.85	95.3	88.937	72.0762
2015	7	13	3	3	6	0.3	3.9	0.81	97.2	88.937	68.4585
2015	7	13	3	13	6	0.3	3.9	0.82	96.9	88.937	69.2933
2015	7	13	3	23	6	0.3	3.9	0.86	95	88.937	72.9111
2015	7	13	3	33	6	0.3	3.9	0.8	95.2	88.937	67.9019
2015	7	13	3	43	6	0.3	3.9	0.81	95.6	88.937	68.4585
2015	7	13	3	53	6	0.3	3.9	0.82	97.1	88.937	69.0151
2015	7	13	4	3	6	0.3	3.9	0.79	98.6	88.937	66.2323
2015	7	13	4	13	6	0.3	3.9	0.83	94.5	88.937	70.1283
2015	7	13	4	23	6	0.3	3.9	0.82	96	88.937	69.0152
2015	7	13	4	33	6	0.3	3.9	0.79	94.3	88.937	66.7889
2015	7	13	4	43	6	0.3	3.9	0.77	94.6	88.937	65.1192
2015	7	13	4	53	6	0.3	3.9	0.84	95.4	88.937	70.9632
2015	7	13	5	3	6	0.3	3.9	0.79	95.7	88.937	67.0672
2015	7	13	5	13	6	0.3	3.9	0.75	95	88.937	63.4495
2015	7	13	5	23	6	0.3	3.9	0.83	96.6	88.937	69.8502
2015	7	13	5	33	6	0.3	3.9	0.84	96.1	88.937	70.685
2015	7	13	5	43	6	0.3	3.9	0.84	98.3	88.937	70.4068
2015	7	13	5	53	6	0.3	3.9	0.83	95.2	88.937	70.4068
2015	7	13	6	3	6	0.3	3.9	0.79	97.4	88.937	66.5108
2015	7	13	6	13	6	0.3	3.9	0.84	96.1	88.937	70.6851
2015	7	13	6	23	6	0.3	3.9	0.85	96	88.937	71.52
2015	7	13	6	33	6	0.3	3.9	0.83	95	88.937	70.1285
2015	7	13	6	43	6	0.3	3.9	0.85	96.2	88.937	71.7983
2015	7	13	6	53	6	0.3	3.9	0.82	96.9	88.937	68.7371
2015	7	13	7	3	6	0.3	3.9	0.81	98.6	89.0026	68.233
2015	7	13	7	13	6	0.3	3.9	0.82	93.2	89.0026	69.6256
2015	7	13	7	23	6	0.3	3.9	0.84	96	89.0026	71.0181
2015	7	13	7	33	6	0.3	3.9	0.83	93.2	89.0026	70.7396
2015	7	13	7	43	6	0.3	3.9	0.82	97.4	89.0026	68.7901
2015	7	13	7	53	6	0.3	3.9	0.79	97.7	89.0026	66.2835
2015	7	13	8	3	6	0.3	3.9	0.8	94.2	89.0026	67.676
2015	7	13	8	13	6	0.3	3.9	0.81	95.3	89.0026	68.5116
2015	7	13	8	23	6	0.3	3.9	0.8	94.5	89.0026	67.9545
2015	7	13	8	33	6	0.3	3.9	0.84	97.2	89.0026	71.0181
2015	7	13	8	43	6	0.3	3.9	0.79	95.7	89.0026	67.119
2015	7	13	8	53	6	0.3	3.9	0.8	97.1	89.0026	67.3975
2015	7	13	9	3	6	0.3	3.9	0.77	97.1	89.0026	65.1695
2015	7	13	9	13	6	0.3	3.9	0.85	95.8	89.0683	71.9088
2015	7	13	9	23	6	0.3	3.9	0.83	96.4	89.0026	69.904
2015	7	13	9	33	6	0.3	3.9	0.82	96.7	89.0683	69.1216

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	13	9	43	6	0.3	3.9	0.83	96.4	89.0683	69.9577
2015	7	13	9	53	6	0.3	3.9	0.83	95.9	89.0683	69.9577
2015	7	13	10	3	6	0.3	3.9	0.8	96.8	89.0683	67.7279
2015	7	13	10	13	6	0.3	3.9	0.81	96.5	89.0683	68.0066
2015	7	13	10	23	6	0.3	3.9	0.79	95.7	89.0683	66.613
2015	7	13	10	33	6	0.3	3.9	0.81	97	89.0683	68.2853
2015	7	13	10	43	6	0.3	3.9	0.85	97.1	89.0683	71.6299
2015	7	13	10	53	6	0.3	3.9	0.8	95.6	89.0683	68.0065
2015	7	13	11	3	6	0.3	3.9	0.85	96.4	89.0683	71.9085
2015	7	13	11	13	6	0.3	3.9	0.85	95.3	89.0683	71.6298
2015	7	13	11	23	6	0.3	3.9	0.85	98.3	89.0683	71.0723
2015	7	13	11	33	6	0.3	3.9	0.79	96.4	89.0683	66.6128
2015	7	13	11	43	6	0.3	3.9	0.86	97.2	89.0683	72.7446
2015	7	13	11	53	6	0.3	3.9	0.78	95.8	89.0683	65.7766
2015	7	13	12	3	6	0.3	3.9	0.82	95.5	89.0683	69.1212
2015	7	13	12	13	6	0.3	3.9	0.78	95.8	89.0683	65.7766
2015	7	13	12	23	6	0.3	3.9	0.8	98.7	89.0683	67.4488
2015	7	13	12	33	6	0.3	3.9	0.8	96.6	89.0683	67.1701
2015	7	13	12	43	6	0.3	3.9	0.81	97	89.0683	68.0062
2015	7	13	12	53	6	0.3	3.9	0.77	96.2	89.0683	64.6616
2015	7	13	13	3	6	0.3	3.9	0.81	98.4	89.0683	67.7274
2015	7	13	13	13	6	0.3	3.9	0.79	94.8	89.0683	66.6126
2015	7	13	13	23	6	0.3	3.9	0.77	99.3	89.0683	64.9402
2015	7	13	13	33	6	0.3	3.9	0.8	94.3	89.0683	67.4486
2015	7	13	13	43	6	0.3	3.9	0.83	96.6	89.0683	70.2357
2015	7	13	13	53	6	0.3	3.9	0.78	94.6	89.0026	66.2828
2015	7	13	14	3	6	0.3	3.9	0.82	96.2	89.0683	68.8421
2015	7	13	14	13	6	0.3	3.9	0.82	97.3	89.0683	69.3995
2015	7	13	14	23	6	0.3	3.9	0.82	98.1	89.0683	68.5633
2015	7	13	14	33	6	0.3	3.9	0.78	98.9	89.0683	65.7762
2015	7	13	14	43	6	0.3	3.9	0.78	98	89.0026	65.4471
2015	7	13	14	53	6	0.3	3.9	0.8	96.4	89.0683	67.1697
2015	7	13	15	3	6	0.3	3.9	0.81	97	89.0026	68.5105
2015	7	13	15	13	6	0.3	3.9	0.82	96.7	89.0026	69.0675
2015	7	13	15	23	6	0.3	3.9	0.77	96.2	89.0683	64.6612
2015	7	13	15	33	6	0.3	3.9	0.79	96.9	89.0026	66.8395
2015	7	13	15	43	6	0.3	3.9	0.79	96.4	89.0026	66.561
2015	7	13	15	53	6	0.3	3.9	0.8	94.7	89.0026	67.675
2015	7	13	16	3	6	0.3	3.9	0.81	96.8	89.0026	67.9535
2015	7	13	16	13	6	0.3	3.9	0.8	98	89.0026	67.118
2015	7	13	16	23	6	0.3	3.9	0.75	96.5	89.0026	63.4975
2015	7	13	16	33	6	0.3	3.9	0.79	98.8	89.0026	66.5609
2015	7	13	16	43	6	0.3	3.9	0.79	96.7	89.0026	66.8394
2015	7	13	16	53	6	0.3	3.9	0.81	98.2	89.0026	67.9534
2015	7	13	17	3	6	0.3	3.9	0.75	97.8	89.0026	62.6619
2015	7	13	17	13	6	0.3	3.9	0.81	94	89.0026	68.5104
2015	7	13	17	23	6	0.3	3.9	0.83	96.1	89.0026	70.4599

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	13	17	33	6	0.3	3.9	0.74	95.6	89.0026	62.9405
2015	7	13	17	43	6	0.3	3.9	0.82	98.3	89.0026	68.7889
2015	7	13	17	53	6	0.3	3.9	0.75	95.3	89.0026	63.2189
2015	7	13	18	3	6	0.3	3.9	0.77	97.8	89.0026	64.8899
2015	7	13	18	13	6	0.3	3.9	0.83	97.5	89.0026	69.6244
2015	7	13	18	23	6	0.3	3.9	0.77	95.4	89.0026	65.1684
2015	7	13	18	33	6	0.3	3.9	0.8	96.1	89.0026	67.6749
2015	7	13	18	43	6	0.3	3.9	0.79	96.2	89.0026	66.2824
2015	7	13	18	53	6	0.3	3.9	0.8	95	89.0026	67.3964
2015	7	13	19	3	6	0.3	3.9	0.82	94.6	89.0026	69.3459
2015	7	13	19	13	6	0.3	3.9	0.79	96	89.0026	66.2824
2015	7	13	19	23	6	0.3	3.9	0.83	96.1	89.0026	69.9029
2015	7	13	19	33	6	0.3	3.9	0.78	94.6	89.0026	66.2824
2015	7	13	19	43	6	0.3	3.9	0.8	97.3	89.0026	67.3964
2015	7	13	19	53	6	0.3	3.9	0.81	97	89.0026	68.5104
2015	7	13	20	3	6	0.3	3.9	0.83	95.5	89.0683	69.9566
2015	7	13	20	13	6	0.3	3.9	0.84	96	89.0683	71.3502
2015	7	13	20	23	6	0.3	3.9	0.82	93.4	89.0683	69.3992
2015	7	13	20	33	6	0.3	3.9	0.81	94.6	89.0683	68.5631
2015	7	13	20	43	6	0.3	3.9	0.79	96.2	89.0683	66.3334
2015	7	13	20	53	6	0.3	3.9	0.82	95.9	89.0683	69.6779
2015	7	13	21	3	6	0.3	3.9	0.82	93.2	89.0683	69.3992
2015	7	13	21	13	6	0.3	3.9	0.84	96.3	89.0683	70.5141
2015	7	13	21	23	6	0.3	3.9	0.85	96.4	89.0683	71.629
2015	7	13	21	33	6	0.3	3.9	0.83	96.1	89.0683	70.5141
2015	7	13	21	43	6	0.3	3.9	0.82	95	89.0683	69.3993
2015	7	13	21	53	6	0.3	3.9	0.77	96.2	89.0683	64.6612
2015	7	13	22	3	6	0.3	3.9	0.78	95.5	89.0683	66.3335
2015	7	13	22	13	6	0.3	3.9	0.81	96.3	89.1339	68.058
2015	7	13	22	23	6	0.3	3.9	0.77	97.8	89.1339	65.2687
2015	7	13	22	33	6	0.3	3.9	0.8	95.6	89.1339	68.058
2015	7	13	22	43	6	0.3	3.9	0.77	98.5	89.1339	64.9898
2015	7	13	22	53	6	0.3	3.9	0.82	97.8	89.1339	68.8948
2015	7	13	23	3	6	0.3	3.9	0.79	96.2	89.1339	66.9423
2015	7	13	23	13	6	0.3	3.9	0.78	97.2	89.1339	66.1056
2015	7	13	23	23	6	0.3	3.9	0.78	98.2	89.1339	65.8267
2015	7	13	23	33	6	0.3	3.9	0.77	96.9	89.1339	64.9899
2015	7	13	23	43	6	0.3	3.9	0.78	96.1	89.1339	65.5477
2015	7	13	23	53	6	0.3	3.9	0.78	96.5	89.1339	65.8267
2015	7	14	0	3	6	0.3	3.9	0.82	97.3	89.1995	69.506
2015	7	14	0	13	6	0.3	3.9	0.85	95.8	89.1995	71.7392
2015	7	14	0	23	6	0.3	3.9	0.79	95.2	89.1995	67.2729
2015	7	14	0	33	6	0.3	3.9	0.75	94.7	89.1995	63.9232
2015	7	14	0	43	6	0.3	3.9	0.81	96.1	89.1995	68.3895
2015	7	14	0	53	6	0.3	3.9	0.75	96.5	89.1995	63.365
2015	7	14	1	3	6	0.3	3.9	0.8	96.4	89.1995	67.273
2015	7	14	1	13	6	0.3	3.9	0.82	95.5	89.1995	69.2269

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	14	1	23	6	0.3	3.9	0.88	97	89.2651	74.5878
2015	7	14	1	33	6	0.3	3.9	0.78	93.6	89.2651	66.4865
2015	7	14	1	43	6	0.3	3.9	0.82	94.6	89.3307	69.6128
2015	7	14	1	53	6	0.3	3.9	0.81	96	89.3963	69.1065
2015	7	14	2	3	6	0.3	3.9	0.84	96.3	89.462	71.3994
2015	7	14	2	13	6	0.3	3.9	0.85	99.1	89.462	71.9595
2015	7	14	2	23	6	0.3	3.9	0.85	94.9	89.5276	72.5749
2015	7	14	2	33	6	0.3	3.9	0.82	96.5	89.5276	69.2124
2015	7	14	2	43	6	0.3	3.9	0.82	96.9	89.5276	69.2124
2015	7	14	2	53	6	0.3	3.9	0.85	96.2	89.5276	72.0146
2015	7	14	3	3	6	0.3	3.9	0.81	93.2	89.5276	69.4927
2015	7	14	3	13	6	0.3	3.9	0.83	97.5	89.5276	70.6135
2015	7	14	3	23	6	0.3	3.9	0.87	95.2	89.5932	74.3131
2015	7	14	3	33	6	0.3	3.9	0.79	98.1	89.5932	67.022
2015	7	14	3	43	6	0.3	3.9	0.85	95.8	89.5932	72.3501
2015	7	14	3	53	6	0.3	3.9	0.82	96.4	89.5932	69.5459
2015	7	14	4	3	6	0.3	3.9	0.87	94.7	89.5932	74.3131
2015	7	14	4	13	6	0.3	3.9	0.85	94.7	89.5932	72.3502
2015	7	14	4	23	6	0.3	3.9	0.84	96.3	89.5932	70.9481
2015	7	14	4	33	6	0.3	3.9	0.84	96.7	89.5932	71.2285
2015	7	14	4	43	6	0.3	3.9	0.78	98.9	89.5932	66.1808
2015	7	14	4	53	6	0.3	3.9	0.82	96.7	89.5932	69.2656
2015	7	14	5	3	6	0.3	3.9	0.83	97.5	89.5932	70.3873
2015	7	14	5	13	6	0.3	4.3	0.85	97.3	89.6588	72.4056
2015	7	14	5	23	6	0.3	4.3	0.81	97.5	89.6588	68.4766
2015	7	14	5	33	6	0.3	4.3	0.81	96.8	89.6588	68.7573
2015	7	14	5	43	6	0.3	4.3	0.83	95.9	89.6588	70.4412
2015	7	14	5	53	6	0.3	4.3	0.87	96.7	89.6588	73.8089
2015	7	14	6	3	6	0.3	4.3	0.84	96.5	89.6588	71.2831
2015	7	14	6	13	6	0.3	4.3	0.83	96.8	89.6588	70.1606
2015	7	14	6	23	6	0.3	4.3	0.82	98	89.6588	69.88
2015	7	14	6	33	6	0.3	4.3	0.82	98.8	89.6588	69.038
2015	7	14	6	43	6	0.3	4.3	0.81	95.8	89.6588	69.3187
2015	7	14	6	53	6	0.3	4.3	0.84	96.7	89.6588	71.5639
2015	7	14	7	3	6	0.3	4.3	0.85	96.9	89.6588	72.4058
2015	7	14	7	13	6	0.3	4.3	0.84	96.9	89.6588	71.5639
2015	7	14	7	23	6	0.3	4.3	0.83	97.1	89.6588	70.1607
2015	7	14	7	33	6	0.3	4.3	0.86	98.4	89.6588	72.4058
2015	7	14	7	43	6	0.3	4.3	0.8	94.9	89.6588	68.1962
2015	7	14	7	53	6	0.3	4.3	0.82	97.8	89.6588	69.3188
2015	7	14	8	3	6	0.3	4.3	0.87	97	89.6588	73.5284
2015	7	14	8	13	6	0.3	4.3	0.82	97.3	89.6588	69.8801
2015	7	14	8	23	6	0.3	4.3	0.83	98.2	89.6588	70.4414
2015	7	14	8	33	6	0.3	4.3	0.85	96.2	89.6588	72.4059
2015	7	14	8	43	6	0.3	4.3	0.84	97.4	89.6588	71.0026
2015	7	14	8	53	6	0.3	4.3	0.8	98	89.6588	67.9156
2015	7	14	9	3	6	0.3	4.3	0.79	99.9	89.6588	66.2317

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	14	9	13	6	0.3	4.3	0.82	96.2	89.6588	70.1607
2015	7	14	9	23	6	0.3	4.3	0.79	96.9	89.6588	67.3542
2015	7	14	9	33	6	0.3	4.3	0.87	97	89.6588	73.5283
2015	7	14	9	43	6	0.3	4.3	0.83	97.5	89.6588	70.1606
2015	7	14	9	53	6	0.3	4.3	0.78	95.1	89.6588	66.2316
2015	7	14	10	3	6	0.3	4.3	0.83	94.6	89.7244	70.495
2015	7	14	10	13	6	0.3	4.3	0.83	97.7	89.7244	70.2141
2015	7	14	10	23	6	0.3	4.3	0.82	99.9	89.6588	69.0379
2015	7	14	10	33	6	0.3	4.3	0.84	97.2	89.7244	71.6183
2015	7	14	10	43	6	0.3	4.3	0.82	98.9	89.6588	69.5992
2015	7	14	10	53	6	0.3	4.3	0.79	96.9	89.7244	66.8437
2015	7	14	11	3	6	0.3	4.3	0.82	98.1	89.6588	69.3185
2015	7	14	11	13	6	0.3	4.3	0.79	97.1	89.6588	67.354
2015	7	14	11	23	6	0.3	4.3	0.82	97.4	89.6588	69.3184
2015	7	14	11	33	6	0.3	4.3	0.84	98.5	89.7244	71.0564
2015	7	14	11	43	6	0.3	4.3	0.82	98.1	89.6588	69.0377
2015	7	14	11	53	6	0.3	4.3	0.82	95.3	89.6588	69.599
2015	7	14	12	3	6	0.3	4.3	0.84	95.6	89.6588	71.2828
2015	7	14	12	13	6	0.3	4.3	0.8	98	89.6588	67.9151
2015	7	14	12	23	6	0.3	4.3	0.81	98	89.6588	68.1957
2015	7	14	12	33	6	0.3	4.3	0.82	96.4	89.6588	69.5989
2015	7	14	12	43	6	0.3	4.3	0.77	95.6	89.6588	65.9505
2015	7	14	12	53	6	0.3	4.3	0.8	96.8	89.6588	67.9149
2015	7	14	13	3	6	0.3	4.3	0.76	95.4	89.6588	65.1085
2015	7	14	13	13	6	0.3	4.3	0.79	97.6	89.6588	67.073
2015	7	14	13	23	6	0.3	4.3	0.82	95.8	89.6588	69.5987
2015	7	14	13	33	6	0.3	3.9	0.81	98.4	89.5932	68.1434
2015	7	14	13	43	6	0.3	3.9	0.78	95.5	89.5932	66.4608
2015	7	14	13	53	6	0.3	4.3	0.77	97.1	89.6588	65.6696
2015	7	14	14	3	6	0.3	3.9	0.82	94.4	89.5932	69.5454
2015	7	14	14	13	6	0.3	3.9	0.82	97.2	89.5932	69.265
2015	7	14	14	23	6	0.3	3.9	0.8	96.3	89.5276	68.0912
2015	7	14	14	33	6	0.3	3.9	0.79	95.5	89.5276	66.9704
2015	7	14	14	43	6	0.3	3.9	0.82	94.6	89.5276	69.4922
2015	7	14	14	53	6	0.3	3.9	0.8	97.1	89.462	67.4791
2015	7	14	15	3	6	0.3	3.9	0.8	94.7	89.462	68.3191
2015	7	14	15	13	6	0.3	3.9	0.8	96.6	89.462	67.7591
2015	7	14	15	23	6	0.3	3.9	0.75	96.8	89.462	63.2791
2015	7	14	15	33	6	0.3	3.9	0.78	95.8	89.3963	66.0285
2015	7	14	15	43	6	0.3	3.9	0.78	96.1	89.3963	65.7487
2015	7	14	15	53	6	0.3	3.9	0.75	96.3	89.3963	63.7902
2015	7	14	16	3	6	0.3	3.9	0.82	96.6	89.3307	69.6123
2015	7	14	16	13	6	0.3	3.9	0.8	96.3	89.3307	67.9349
2015	7	14	16	23	6	0.3	3.9	0.8	94.3	89.3963	67.7071
2015	7	14	16	33	6	0.3	3.9	0.8	94.5	89.3307	68.2144
2015	7	14	16	43	6	0.3	3.9	0.79	96.2	89.3307	66.8166
2015	7	14	16	53	6	0.3	3.9	0.82	96.4	89.2651	69.5589

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	14	17	3	6	0.3	3.9	0.82	96.9	89.2651	69.2796
2015	7	14	17	13	6	0.3	3.9	0.81	96.8	89.2651	68.1622
2015	7	14	17	23	6	0.3	3.9	0.8	96.8	89.2651	67.8828
2015	7	14	17	33	6	0.3	3.9	0.8	97.8	89.3307	67.6553
2015	7	14	17	43	6	0.3	3.9	0.79	99.3	89.2651	66.486
2015	7	14	17	53	6	0.3	3.9	0.81	96.8	89.2651	68.1622
2015	7	14	18	3	6	0.3	3.9	0.77	96.8	89.1995	65.3185
2015	7	14	18	13	6	0.3	3.9	0.79	97.9	89.1995	66.7142
2015	7	14	18	23	6	0.3	3.9	0.78	98.3	89.1995	65.3185
2015	7	14	18	33	6	0.3	3.9	0.83	97.7	89.2651	70.397
2015	7	14	18	43	6	0.3	3.9	0.76	97	89.2651	63.9718
2015	7	14	18	53	6	0.3	3.9	0.77	95.9	89.2651	65.3686
2015	7	14	19	3	6	0.3	3.9	0.75	96.3	89.1995	63.6437
2015	7	14	19	13	6	0.3	3.9	0.78	94.6	89.1995	65.8768
2015	7	14	19	23	6	0.3	3.9	0.75	97.6	89.1995	63.0854
2015	7	14	19	33	6	0.3	3.9	0.79	97.2	89.2651	66.7654
2015	7	14	19	43	6	0.3	3.9	0.8	97.8	89.2651	67.6034
2015	7	14	19	53	6	0.3	3.9	0.77	99	89.2651	65.0893
2015	7	14	20	3	6	0.3	3.9	0.81	93.7	89.2651	68.4415
2015	7	14	20	13	6	0.3	3.9	0.76	95.9	89.2651	64.5306
2015	7	14	20	23	6	0.3	3.9	0.78	97.5	89.2651	65.648
2015	7	14	20	33	6	0.3	3.9	0.79	95	89.3307	66.8166
2015	7	14	20	43	6	0.3	3.9	0.78	99	89.3307	65.4187
2015	7	14	20	53	6	0.3	3.9	0.79	95.9	89.3307	67.3757
2015	7	14	21	3	6	0.3	3.9	0.79	96.2	89.3963	66.8678
2015	7	14	21	13	6	0.3	3.9	0.76	96.9	89.3963	64.3497
2015	7	14	21	23	6	0.3	3.9	0.75	98.3	89.3963	62.9508
2015	7	14	21	33	6	0.3	3.9	0.81	95.6	89.5276	68.6514
2015	7	14	21	43	6	0.3	3.9	0.76	96.7	89.5932	64.778
2015	7	14	21	53	6	0.3	4.3	0.79	95.5	89.6588	67.3532
2015	7	14	22	3	6	0.3	3.9	0.84	96.5	89.5932	71.2277
2015	7	14	22	13	6	0.3	4.3	0.77	96.6	89.6588	65.6694
2015	7	14	22	23	6	0.3	4.3	0.79	96.5	89.7244	66.8429
2015	7	14	22	33	6	0.3	4.3	0.79	97.1	89.7244	67.4046
2015	7	14	22	43	6	0.3	4.3	0.84	97.7	89.7244	71.0557
2015	7	14	22	53	6	0.3	4.3	0.77	96.2	89.79	65.2076
2015	7	14	23	3	6	0.3	4.3	0.79	98.1	89.8556	66.9449
2015	7	14	23	13	6	0.3	4.3	0.79	95.5	89.8556	67.2262
2015	7	14	23	23	6	0.3	4.3	0.84	95.4	89.8556	72.008
2015	7	14	23	33	6	0.3	4.3	0.82	97.4	89.8556	69.7578
2015	7	14	23	43	6	0.3	4.3	0.84	97.6	89.8556	71.4455
2015	7	14	23	53	6	0.3	4.3	0.88	97.3	89.9213	74.8778
2015	7	15	0	3	6	0.3	4.3	0.81	96.8	89.9213	68.9664
2015	7	15	0	13	6	0.3	4.3	0.84	97.6	89.9869	71.836
2015	7	15	0	23	6	0.3	4.3	0.77	98.4	89.9869	65.075
2015	7	15	0	33	6	0.3	4.3	0.78	99.7	90.0525	65.9703
2015	7	15	0	43	6	0.3	4.3	0.81	97	90.0525	68.7895

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	15	0	53	6	0.3	4.3	0.82	96.7	90.1181	69.9703
2015	7	15	1	3	6	0.3	4.3	0.82	96.4	90.315	70.4125
2015	7	15	1	13	6	0.3	4.3	0.84	95.6	90.3806	72.4468
2015	7	15	1	23	6	0.3	4.3	0.83	96.3	90.4462	71.3688
2015	7	15	1	33	6	0.3	4.3	0.87	96.3	90.4462	74.4841
2015	7	15	1	43	6	0.3	4.3	0.83	95.9	90.5118	71.7063
2015	7	15	1	53	6	0.3	4.3	0.84	95.4	90.5118	71.9897
2015	7	15	2	3	6	0.3	4.3	0.8	96.8	90.5774	68.9241
2015	7	15	2	13	6	0.3	4.3	0.84	95.4	90.5774	72.6114
2015	7	15	2	23	6	0.3	4.3	0.88	94.7	90.5774	75.4478
2015	7	15	2	33	6	0.3	4.3	0.86	96.1	90.6431	74.3694
2015	7	15	2	43	6	0.3	4.3	0.89	96.8	90.6431	76.0725
2015	7	15	2	53	6	0.3	4.3	0.82	100.1	90.6431	70.1116
2015	7	15	3	3	6	0.3	4.3	0.81	95.3	90.7087	70.1646
2015	7	15	3	13	6	0.3	4.3	0.81	97.5	90.7743	69.3647
2015	7	15	3	23	6	0.3	4.3	0.87	96.7	90.7743	74.4817
2015	7	15	3	33	6	0.3	4.3	0.78	95.5	90.7743	67.659
2015	7	15	3	43	6	0.3	4.3	0.86	96.4	90.8399	73.9689
2015	7	15	3	53	6	0.3	4.3	0.83	97.2	91.0368	71.855
2015	7	15	4	3	6	0.3	4.3	0.86	96.4	91.1024	73.9065
2015	7	15	4	13	6	0.3	4.3	0.88	95.8	91.168	75.961
2015	7	15	4	23	6	0.3	4.3	0.88	99.3	91.168	75.3898
2015	7	15	4	33	6	0.3	4.3	0.86	96.3	91.2336	74.8749
2015	7	15	4	43	6	0.3	4.3	0.86	96.3	91.2336	74.8749
2015	7	15	4	53	6	0.3	4.3	0.86	95.9	91.2992	74.6451
2015	7	15	5	3	6	0.3	4.3	0.76	97.4	91.2992	66.0652
2015	7	15	5	13	6	0.3	4.3	0.86	96.3	91.2992	74.6451
2015	7	15	5	23	6	0.3	4.3	0.82	93.7	91.3648	71.5527
2015	7	15	5	33	6	0.3	4.3	0.89	96.6	91.3648	76.7046
2015	7	15	5	43	6	0.3	4.3	0.84	97.8	91.3648	72.6976
2015	7	15	5	53	6	0.3	4.3	0.87	96	91.3648	75.846
2015	7	15	6	3	6	0.3	4.3	0.82	95	91.4305	71.32
2015	7	15	6	13	6	0.3	4.3	0.9	96.9	91.4305	77.6214
2015	7	15	6	23	6	0.3	4.3	0.86	96.6	91.4305	74.1843
2015	7	15	6	33	6	0.3	4.3	0.85	94.9	91.4961	73.6665
2015	7	15	6	43	6	0.3	4.3	0.86	95.9	91.4961	75.0998
2015	7	15	6	53	6	0.3	4.3	0.86	96.3	91.6929	74.981
2015	7	15	7	3	6	0.3	4.3	0.87	95.6	91.7585	76.1869
2015	7	15	7	13	6	0.3	4.3	0.87	96.5	91.8242	75.3806
2015	7	15	7	23	6	0.3	4.3	0.84	97.4	91.8242	72.7912
2015	7	15	7	33	6	0.3	4.3	0.87	97.2	91.8898	75.7247
2015	7	15	7	43	6	0.3	4.3	0.84	95	91.8898	73.1334
2015	7	15	7	53	6	0.3	4.3	0.82	97.4	91.9554	71.1708
2015	7	15	8	3	6	0.3	4.3	0.9	96.2	91.9554	78.9506
2015	7	15	8	13	6	0.3	4.3	0.82	96.6	91.9554	71.7471
2015	7	15	8	23	6	0.3	4.3	0.82	95.3	92.021	72.0888
2015	7	15	8	33	6	0.3	4.3	0.85	96	92.021	74.684

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	15	8	43	6	0.3	4.3	0.79	95.7	92.021	69.2053
2015	7	15	8	53	6	0.3	4.3	0.85	96.7	92.021	74.1073
2015	7	15	9	3	6	0.3	4.3	0.84	95.4	92.021	73.8189
2015	7	15	9	13	6	0.3	4.3	0.83	95.5	92.021	72.3772
2015	7	15	9	23	6	0.3	4.3	0.83	94.8	92.0866	72.4309
2015	7	15	9	33	6	0.3	4.3	0.86	97.4	92.0866	75.3166
2015	7	15	9	43	6	0.3	4.3	0.85	98.8	92.0866	74.1623
2015	7	15	9	53	6	0.3	4.3	0.87	97.6	92.0866	76.1823
2015	7	15	10	3	6	0.3	4.3	0.86	96.6	92.1522	75.3725
2015	7	15	10	13	6	0.3	4.3	0.86	97.2	92.1522	75.0837
2015	7	15	10	23	6	0.3	4.3	0.85	97.1	92.1522	73.9286
2015	7	15	10	33	6	0.3	4.3	0.85	96.7	92.1522	73.9285
2015	7	15	10	43	6	0.3	4.3	0.87	96.9	92.2179	76.2954
2015	7	15	10	53	6	0.3	4.3	0.84	96.7	92.2179	73.4054
2015	7	15	11	3	6	0.3	4.3	0.85	96.4	92.2179	74.5613
2015	7	15	11	13	6	0.3	4.3	0.83	95.7	92.2179	72.5383
2015	7	15	11	23	6	0.3	4.3	0.78	97.2	92.2179	68.4923
2015	7	15	11	33	6	0.3	4.3	0.87	96.5	92.2835	76.3518
2015	7	15	11	43	6	0.3	4.3	0.85	96.9	92.2835	74.3273
2015	7	15	11	53	6	0.3	4.3	0.79	97.6	92.2179	69.0702
2015	7	15	12	3	6	0.3	4.3	0.84	98.3	92.2835	73.4596
2015	7	15	12	13	6	0.3	4.3	0.83	97.5	92.2835	72.8812
2015	7	15	12	23	6	0.3	4.3	0.84	94.5	92.2835	74.038
2015	7	15	12	33	6	0.3	4.3	0.87	96.3	92.2835	76.0624
2015	7	15	12	43	6	0.3	4.3	0.83	97.1	92.2835	72.3026
2015	7	15	12	53	6	0.3	4.3	0.82	97.8	92.2835	72.0134
2015	7	15	13	3	6	0.3	4.3	0.83	97	92.2835	72.881
2015	7	15	13	13	6	0.3	4.3	0.85	97.3	92.2835	74.327
2015	7	15	13	23	6	0.3	4.3	0.84	97.2	92.3491	73.5138
2015	7	15	13	33	6	0.3	4.3	0.86	96.6	92.2835	74.9054
2015	7	15	13	43	6	0.3	4.3	0.8	94.5	92.3491	70.6195
2015	7	15	13	53	6	0.3	4.3	0.83	96.8	92.3491	72.6454
2015	7	15	14	3	6	0.3	4.3	0.82	96.9	92.3491	72.0665
2015	7	15	14	13	6	0.3	4.3	0.84	98	92.3491	73.8031
2015	7	15	14	23	6	0.3	4.3	0.82	96	92.3491	72.0665
2015	7	15	14	33	6	0.3	4.3	0.83	98.4	92.3491	72.6453
2015	7	15	14	43	6	0.3	4.3	0.81	96.5	92.3491	70.9087
2015	7	15	14	53	6	0.3	4.3	0.84	95.4	92.3491	73.5135
2015	7	15	15	3	6	0.3	4.3	0.86	95.5	92.3491	75.5395
2015	7	15	15	13	6	0.3	4.3	0.8	97.3	92.3491	70.0404
2015	7	15	15	23	6	0.3	4.3	0.82	95.5	92.3491	71.777
2015	7	15	15	33	6	0.3	4.3	0.8	98	92.3491	70.0404
2015	7	15	15	43	6	0.3	4.3	0.84	97.2	92.3491	73.224
2015	7	15	15	53	6	0.3	4.3	0.82	95.3	92.4147	72.4093
2015	7	15	16	3	6	0.3	4.3	0.84	97.6	92.3491	73.5134
2015	7	15	16	13	6	0.3	4.3	0.84	96.3	92.3491	73.5134
2015	7	15	16	23	6	0.3	4.3	0.76	97.2	92.3491	66.8567

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	15	16	33	6	0.3	4.3	0.82	97.1	92.3491	72.0663
2015	7	15	16	43	6	0.3	4.3	0.83	95	92.3491	73.224
2015	7	15	16	53	6	0.3	4.3	0.82	96.7	92.3491	71.4874
2015	7	15	17	3	6	0.3	4.3	0.87	97.8	92.3491	75.8288
2015	7	15	17	13	6	0.3	4.3	0.82	98	92.3491	71.7769
2015	7	15	17	23	6	0.3	4.3	0.82	98.9	92.3491	71.7769
2015	7	15	17	33	6	0.3	4.3	0.81	96.8	92.3491	70.6192
2015	7	15	17	43	6	0.3	4.3	0.76	95.7	92.3491	67.1461
2015	7	15	17	53	6	0.3	4.3	0.8	96.9	92.3491	69.7509
2015	7	15	18	3	6	0.3	4.3	0.81	96.5	92.3491	70.6192
2015	7	15	18	13	6	0.3	4.3	0.79	98.2	92.3491	68.5932
2015	7	15	18	23	6	0.3	4.3	0.84	96.3	92.3491	73.5134
2015	7	15	18	33	6	0.3	4.3	0.8	96.8	92.3491	70.3298
2015	7	15	18	43	6	0.3	4.3	0.81	97.2	92.3491	70.9086
2015	7	15	18	53	6	0.3	4.3	0.85	95.5	92.3491	74.6711
2015	7	15	19	3	6	0.3	4.3	0.8	94.7	92.3491	70.6192
2015	7	15	19	13	6	0.3	4.3	0.85	94.6	92.3491	74.9605
2015	7	15	19	23	6	0.3	4.3	0.8	96.9	92.3491	69.7509
2015	7	15	19	33	6	0.3	4.3	0.8	95.2	92.3491	70.6192
2015	7	15	19	43	6	0.3	4.3	0.85	94.7	92.3491	74.3817
2015	7	15	19	53	6	0.3	4.3	0.83	94.3	92.3491	73.224
2015	7	15	20	3	6	0.3	4.3	0.81	95.1	92.3491	71.198
2015	7	15	20	13	6	0.3	4.3	0.82	97.1	92.3491	72.0663
2015	7	15	20	23	6	0.3	4.3	0.85	96	92.3491	74.6711
2015	7	15	20	33	6	0.3	4.3	0.85	95.1	92.3491	74.3817
2015	7	15	20	43	6	0.3	4.3	0.84	96.5	92.3491	73.224
2015	7	15	20	53	6	0.3	4.3	0.84	96.5	92.3491	73.8028
2015	7	15	21	3	6	0.3	4.3	0.79	97.2	92.4147	69.2233
2015	7	15	21	13	24	0.3	4.3	0.84	98.5	92.4147	73.5679
2015	7	15	21	23	24	0.3	4.3	0.79	94.3	92.3491	69.1721
2015	7	15	21	33	24	0.3	4.3	0.84	98.8	92.3491	72.9346
2015	7	15	21	43	24	0.3	4.3	0.84	97.7	92.4147	73.2783
2015	7	15	21	53	24	0.3	4.3	0.77	97.3	92.4147	67.4855
2015	7	15	22	3	24	0.3	4.3	0.81	96.5	92.4147	70.9612
2015	7	15	22	13	24	0.3	4.3	0.79	97.9	92.4147	69.2233
2015	7	15	22	23	24	0.3	4.3	0.84	97.2	92.4147	73.2783
2015	7	15	22	33	24	0.3	4.3	0.83	96.6	92.4147	72.699
2015	7	15	22	43	24	0.3	4.3	0.81	98.6	92.4147	70.6715
2015	7	15	22	53	24	0.3	4.3	0.82	95.8	92.4147	71.8301
2015	7	15	23	3	24	0.3	4.3	0.77	94.1	92.4147	68.0648
2015	7	15	23	13	24	0.3	4.3	0.81	97.4	92.4147	71.2508
2015	7	15	23	23	24	0.3	4.3	0.81	96.1	92.4147	70.9612
2015	7	15	23	33	24	0.3	4.3	0.86	96.4	92.4147	75.3058
2015	7	15	23	43	24	0.3	4.3	0.79	95.7	92.4147	69.2234
2015	7	15	23	53	24	0.3	4.3	0.84	96.3	92.4803	73.6224
2015	7	16	0	3	24	0.3	4.3	0.85	95.5	92.4147	74.7265
2015	7	16	0	13	24	0.3	4.3	0.81	94.2	92.4803	71.0137

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	16	0	23	24	0.3	4.3	0.79	95.9	92.4803	69.8543
2015	7	16	0	33	24	0.3	4.3	0.87	95.2	92.4803	76.8108
2015	7	16	0	43	24	0.3	4.3	0.8	96.6	92.4803	70.1442
2015	7	16	0	53	24	0.3	4.3	0.89	95.9	92.4803	78.2601
2015	7	16	1	3	24	0.3	4.3	0.82	96.9	92.5459	71.9365
2015	7	16	1	13	24	0.3	4.3	0.88	97.3	92.5459	77.1577
2015	7	16	1	23	24	0.3	4.3	0.84	96.3	92.5459	73.967
2015	7	16	1	33	24	0.3	4.3	0.87	97.8	92.5459	76.2875
2015	7	16	1	43	24	0.3	4.3	0.85	99.1	92.6116	74.0217
2015	7	16	1	53	24	0.3	4.3	0.84	97.4	92.6116	73.4411
2015	7	16	2	3	24	0.3	4.3	0.87	95.6	92.6116	76.9245
2015	7	16	2	13	24	0.3	4.3	0.85	94	92.6772	74.6574
2015	7	16	2	23	24	0.3	4.3	0.84	96	92.6772	74.3669
2015	7	16	2	33	24	0.3	4.3	0.87	96.3	92.6772	76.6909
2015	7	16	2	43	24	0.3	4.3	0.89	95.3	92.6772	78.1433
2015	7	16	2	53	24	0.3	4.3	0.86	95.7	92.6772	75.5289
2015	7	16	3	3	24	0.3	4.3	0.8	94.5	92.6772	70.881
2015	7	16	3	13	24	0.3	4.3	0.88	94.7	92.6772	77.2719
2015	7	16	3	23	24	0.3	4.3	0.9	96.7	92.6772	79.0149
2015	7	16	3	33	24	0.3	4.3	0.88	96.7	92.6772	76.9814
2015	7	16	3	43	24	0.3	4.3	0.83	95	92.6772	73.4955
2015	7	16	3	53	24	0.3	4.3	0.83	95.2	92.7428	73.2591
2015	7	16	4	3	24	0.3	4.3	0.84	93.8	92.6772	74.367
2015	7	16	4	13	24	0.3	4.3	0.88	97.9	92.6772	77.272
2015	7	16	4	23	24	0.3	4.3	0.89	95.1	92.6772	78.434
2015	7	16	4	33	24	0.3	4.3	0.84	97.8	92.6772	73.7861
2015	7	16	4	43	24	0.3	4.3	0.89	96.8	92.6772	78.1436
2015	7	16	4	53	24	0.3	4.3	0.89	96.6	92.6772	77.8531
2015	7	16	5	3	24	0.3	4.3	0.85	97.3	92.6772	74.9482
2015	7	16	5	13	24	0.3	4.3	0.83	95	92.6772	73.4957
2015	7	16	5	23	24	0.3	4.3	0.85	96.9	92.6772	74.9482
2015	7	16	5	33	24	0.3	4.3	0.84	94.9	92.6772	74.3672
2015	7	16	5	43	24	0.3	4.3	0.84	96.3	92.6772	74.0768
2015	7	16	5	53	24	0.3	4.3	0.8	94.7	92.6772	70.3003
2015	7	16	6	3	24	0.3	4.3	0.85	94.2	92.6772	74.6578
2015	7	16	6	13	24	0.3	4.3	0.87	97.8	92.6772	76.4008
2015	7	16	6	23	24	0.3	4.3	0.86	96.3	92.6772	76.1104
2015	7	16	6	33	24	0.3	4.3	0.88	95.2	92.6772	77.2724
2015	7	16	6	43	24	0.3	4.3	0.87	93.7	92.6772	77.2724
2015	7	16	6	53	24	0.3	4.3	0.82	95.7	92.6772	72.334
2015	7	16	7	3	24	0.3	4.3	0.83	95.4	92.6772	73.496
2015	7	16	7	13	24	0.3	4.3	0.79	95.2	92.6772	70.01
2015	7	16	7	23	24	0.3	4.3	0.83	95.4	92.6772	73.496
2015	7	16	7	33	24	0.3	4.3	0.83	94.7	92.6772	73.496
2015	7	16	7	43	24	0.3	4.3	0.83	96.8	92.6772	73.2055
2015	7	16	7	53	24	0.3	4.3	0.86	95.3	92.6772	75.82
2015	7	16	8	3	24	0.3	4.3	0.85	96.7	92.6772	74.658

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	16	8	13	24	0.3	4.3	0.86	96.4	92.6116	75.4738
2015	7	16	8	23	24	0.3	4.3	0.91	97	92.6116	79.8281
2015	7	16	8	33	24	0.3	4.3	0.81	95.1	92.6116	71.7001
2015	7	16	8	43	24	0.3	4.3	0.83	96.4	92.6116	72.571
2015	7	16	8	53	24	0.3	4.3	0.86	96.8	92.6116	75.4738
2015	7	16	9	3	24	0.3	4.3	0.82	97.1	92.6116	71.9904
2015	7	16	9	13	24	0.3	4.3	0.82	97.3	92.6116	72.2806
2015	7	16	9	23	24	0.3	4.3	0.83	97.5	92.5459	72.8074
2015	7	16	9	33	24	0.3	4.3	0.84	95.4	92.5459	74.2577
2015	7	16	9	43	24	0.3	4.3	0.82	95.3	92.4147	71.8308
2015	7	16	9	53	24	0.3	4.3	0.82	97.6	92.4147	71.8308
2015	7	16	10	3	24	0.3	4.3	0.82	98.3	92.3491	71.7776
2015	7	16	10	13	24	0.3	4.3	0.85	95.3	92.3491	74.3825
2015	7	16	10	23	24	0.3	4.3	0.82	95.5	92.3491	72.067
2015	7	16	10	33	24	0.3	4.3	0.85	97.8	92.3491	74.093
2015	7	16	10	43	24	0.3	4.3	0.81	95.8	92.2835	71.146
2015	7	16	10	53	24	0.3	4.3	0.81	98.4	92.2835	70.8567
2015	7	16	11	3	24	0.3	4.3	0.86	96.3	92.2835	75.4841
2015	7	16	11	13	24	0.3	4.3	0.85	96.2	92.2835	74.3272
2015	7	16	11	23	24	0.3	4.3	0.8	96.4	92.2835	69.6998
2015	7	16	11	33	24	0.3	4.3	0.85	94.9	92.2835	74.3271
2015	7	16	11	43	24	0.3	4.3	0.82	97.3	92.2835	72.0134
2015	7	16	11	53	24	0.3	4.3	0.81	97.7	92.2179	70.804
2015	7	16	12	3	24	0.3	4.3	0.79	98.1	92.2179	69.07
2015	7	16	12	13	24	0.3	4.3	0.85	96.4	92.2179	74.5609
2015	7	16	12	23	24	0.3	4.3	0.8	96.6	92.2179	69.937
2015	7	16	12	33	24	0.3	4.3	0.86	94.2	92.2179	75.4279
2015	7	16	12	43	24	0.3	4.3	0.78	95.8	92.2179	68.2029
2015	7	16	12	53	24	0.3	4.3	0.8	96.6	92.2179	69.9369
2015	7	16	13	3	24	0.3	4.3	0.85	96.4	92.2179	74.5608
2015	7	16	13	13	24	0.3	4.3	0.81	96.8	92.2179	70.5148
2015	7	16	13	23	24	0.3	4.3	0.85	98	92.2179	74.2717
2015	7	16	13	33	24	0.3	4.3	0.82	96.9	92.1522	71.6176
2015	7	16	13	43	24	0.3	4.3	0.84	96.5	92.1522	73.639
2015	7	16	13	53	24	0.3	4.3	0.81	96.3	92.1522	70.4624
2015	7	16	14	3	24	0.3	4.3	0.8	96.8	92.1522	70.1736
2015	7	16	14	13	24	0.3	4.3	0.83	95.5	92.1522	72.4838
2015	7	16	14	23	24	0.3	4.3	0.83	97.1	92.1522	72.195
2015	7	16	14	33	24	0.3	4.3	0.77	96.6	92.0866	67.5243
2015	7	16	14	43	24	0.3	4.3	0.78	98.5	92.0866	67.8129
2015	7	16	14	53	24	0.3	4.3	0.84	96.5	92.0866	73.0071
2015	7	16	15	3	24	0.3	4.3	0.82	95.7	92.0866	72.1413
2015	7	16	15	13	24	0.3	4.3	0.81	97.4	92.021	70.646
2015	7	16	15	23	24	0.3	4.3	0.82	97.5	91.9554	71.746
2015	7	16	15	33	24	0.3	4.3	0.81	96.5	91.9554	70.3053
2015	7	16	15	43	24	0.3	4.3	0.84	96	91.9554	73.7629
2015	7	16	15	53	24	0.3	4.3	0.78	97.5	91.9554	68.2883

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	16	16	3	24	0.3	4.3	0.78	96.8	91.9554	67.712
2015	7	16	16	13	24	0.3	4.3	0.81	96.3	91.8898	70.8288
2015	7	16	16	23	24	0.3	4.3	0.84	97.7	91.8242	72.79
2015	7	16	16	33	24	0.3	4.3	0.83	98.7	91.7585	71.5858
2015	7	16	16	43	24	0.3	4.3	0.79	97.4	91.8242	69.0498
2015	7	16	16	53	24	0.3	4.3	0.83	95.6	91.8242	72.79
2015	7	16	17	3	24	0.3	4.3	0.81	94.4	91.7585	70.4358
2015	7	16	17	13	24	0.3	4.3	0.79	97.4	91.7585	68.9984
2015	7	16	17	23	24	0.3	4.3	0.78	98.4	91.7585	67.8484
2015	7	16	17	33	24	0.3	4.3	0.78	94.1	91.7585	68.4234
2015	7	16	17	43	24	0.3	4.3	0.83	95.4	91.6929	72.6816
2015	7	16	17	53	24	0.3	4.3	0.76	95.9	91.6273	66.3119
2015	7	16	18	3	24	0.3	4.3	0.83	97.3	91.6929	71.8198
2015	7	16	18	13	24	0.3	4.3	0.82	96.9	91.6273	71.192
2015	7	16	18	23	24	0.3	4.3	0.85	95.5	91.6273	74.0627
2015	7	16	18	33	24	0.3	4.3	0.81	95.3	91.6273	70.905
2015	7	16	18	43	24	0.3	4.3	0.8	99	91.6273	68.8955
2015	7	16	18	53	24	0.3	4.3	0.81	98.6	91.6273	70.3308
2015	7	16	19	3	24	0.3	4.3	0.86	97	91.6273	74.6368
2015	7	16	19	13	24	0.3	4.3	0.81	98.1	91.6273	70.3309
2015	7	16	19	23	24	0.3	4.3	0.81	95.6	91.6273	70.6179
2015	7	16	19	33	24	0.3	4.3	0.82	95.5	91.5617	71.7126
2015	7	16	19	43	24	0.3	4.3	0.78	94.8	91.5617	68.2704
2015	7	16	19	53	24	0.3	4.3	0.82	97.1	91.5617	71.4258
2015	7	16	20	3	24	0.3	4.3	0.79	96.7	91.5617	68.8441
2015	7	16	20	13	24	0.3	4.3	0.84	97.9	91.5617	72.5732
2015	7	16	20	23	24	0.3	4.3	0.84	98.3	91.5617	72.5732
2015	7	16	20	33	24	0.3	4.3	0.82	96.9	91.5617	71.1389
2015	7	16	20	43	24	0.3	4.3	0.8	97	91.5617	69.7047
2015	7	16	20	53	24	0.3	4.3	0.84	95.8	91.5617	73.1469
2015	7	16	21	3	24	0.3	4.3	0.83	97.5	91.5617	71.7126
2015	7	16	21	13	24	0.3	4.3	0.83	96.6	91.5617	72.2864
2015	7	16	21	23	24	0.3	4.3	0.81	95.8	91.5617	70.5653
2015	7	16	21	33	24	0.3	4.3	0.82	95.5	91.5617	71.7127
2015	7	16	21	43	24	0.3	4.3	0.8	95	91.5617	69.4179
2015	7	16	21	53	24	0.3	4.3	0.83	97.5	91.5617	72.2864
2015	7	16	22	3	24	0.3	4.3	0.78	96.6	91.5617	67.4099
2015	7	16	22	13	24	0.3	4.3	0.8	99	91.5617	68.8442
2015	7	16	22	23	24	0.3	4.3	0.79	95.7	91.5617	68.8442
2015	7	16	22	33	24	0.3	4.3	0.85	95.5	91.5617	74.0075
2015	7	16	22	43	24	0.3	4.3	0.82	95.7	91.5617	71.7127
2015	7	16	22	53	24	0.3	4.3	0.78	98	91.5617	67.1231
2015	7	16	23	3	24	0.3	4.3	0.79	98.1	91.5617	68.5574
2015	7	16	23	13	24	0.3	4.3	0.77	94.6	91.4961	67.3596
2015	7	16	23	23	24	0.3	4.3	0.74	97.6	91.5617	64.5415
2015	7	16	23	33	24	0.3	4.3	0.81	95.6	91.4961	70.226
2015	7	16	23	43	24	0.3	4.3	0.85	95.3	91.4961	73.9523

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	16	23	53	24	0.3	4.3	0.82	97.2	91.5617	70.8522
2015	7	17	0	3	24	0.3	4.3	0.82	94.6	91.5617	71.1391
2015	7	17	0	13	24	0.3	4.3	0.84	96.1	91.4961	72.8058
2015	7	17	0	23	24	0.3	4.3	0.76	96.7	91.5617	66.2627
2015	7	17	0	33	24	0.3	4.3	0.81	96.1	91.5617	69.9917
2015	7	17	0	43	24	0.3	4.3	0.78	95.5	91.5617	67.9838
2015	7	17	0	53	24	0.3	4.3	0.84	95.2	91.5617	72.8603
2015	7	17	1	3	24	0.3	4.3	0.83	96.6	91.5617	71.7129
2015	7	17	1	13	24	0.3	4.3	0.88	94.7	91.4961	76.8187
2015	7	17	1	23	24	0.3	4.3	0.78	97.7	91.5617	67.6969
2015	7	17	1	33	24	0.3	4.3	0.79	94.5	91.5617	68.5575
2015	7	17	1	43	24	0.3	4.3	0.82	97.5	91.5617	71.426
2015	7	17	1	53	24	0.3	4.3	0.87	96.9	91.5617	75.442
2015	7	17	2	3	24	0.3	4.3	0.79	94.5	91.5617	68.5575
2015	7	17	2	13	24	0.3	4.3	0.87	96.3	91.5617	75.442
2015	7	17	2	23	24	0.3	4.3	0.85	97.5	91.5617	73.7209
2015	7	17	2	33	24	0.3	4.3	0.84	97.9	91.5617	72.5735
2015	7	17	2	43	24	0.3	4.3	0.87	97.2	91.5617	75.442
2015	7	17	2	53	24	0.3	4.3	0.84	97.6	91.5617	73.1472
2015	7	17	3	3	24	0.3	4.3	0.85	96	91.5617	74.0078
2015	7	17	3	13	24	0.3	4.3	0.86	94.2	91.5617	74.5815
2015	7	17	3	23	24	0.3	4.3	0.82	97.4	91.4961	71.0862
2015	7	17	3	33	24	0.3	4.3	0.87	96.5	91.5617	75.4421
2015	7	17	3	43	24	0.3	4.3	0.86	96.4	91.4961	74.5259
2015	7	17	3	53	24	0.3	4.3	0.84	96.5	91.5617	73.1474
2015	7	17	4	3	24	0.3	4.3	0.83	95.2	91.5617	72.2868
2015	7	17	4	13	24	0.3	4.3	0.86	95	91.4961	75.0992
2015	7	17	4	23	24	0.3	4.3	0.81	97.2	91.4961	70.2264
2015	7	17	4	33	24	0.3	4.3	0.87	95.2	91.4961	75.9592
2015	7	17	4	43	24	0.3	4.3	0.89	95.1	91.4961	77.679
2015	7	17	4	53	24	0.3	4.3	0.83	97.7	91.4961	71.6597
2015	7	17	5	3	24	0.3	4.3	0.82	96.7	91.4961	70.7998
2015	7	17	5	13	24	0.3	4.3	0.82	95.5	91.4961	71.6597
2015	7	17	5	23	24	0.3	4.3	0.86	96.6	91.4961	74.8128
2015	7	17	5	33	24	0.3	4.3	0.87	96.3	91.4961	75.3861
2015	7	17	5	43	24	0.3	4.3	0.82	97.6	91.4961	71.0865
2015	7	17	5	53	24	0.3	4.3	0.85	96.7	91.4961	73.3797
2015	7	17	6	3	24	0.3	4.3	0.85	96.9	91.4961	73.6663
2015	7	17	6	13	24	0.3	4.3	0.84	96.9	91.4961	73.0931
2015	7	17	6	23	24	0.3	4.3	0.85	96.2	91.4961	73.6664
2015	7	17	6	33	24	0.3	4.3	0.78	94.3	91.4305	67.8828
2015	7	17	6	43	24	0.3	4.3	0.84	95.8	91.4305	73.3249
2015	7	17	6	53	24	0.3	4.3	0.82	98	91.4305	71.32
2015	7	17	7	3	24	0.3	4.3	0.85	96.9	91.4305	73.325
2015	7	17	7	13	24	0.3	4.3	0.84	97.7	91.4305	72.4657
2015	7	17	7	23	24	0.3	4.3	0.83	97.5	91.4305	71.6065
2015	7	17	7	33	24	0.3	4.3	0.86	96.4	91.4305	74.4707

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	17	7	43	24	0.3	4.3	0.82	95.3	91.4305	71.0336
2015	7	17	7	53	24	0.3	4.3	0.89	96.6	91.4305	76.7622
2015	7	17	8	3	24	0.3	4.3	0.87	97	91.4305	75.0436
2015	7	17	8	13	24	0.3	4.3	0.79	94.5	91.4305	68.4558
2015	7	17	8	23	24	0.3	4.3	0.86	97.9	91.4305	74.7572
2015	7	17	8	33	24	0.3	4.3	0.83	97.1	91.4305	71.6065
2015	7	17	8	43	24	0.3	4.3	0.85	97.3	91.3648	73.2702
2015	7	17	8	53	24	0.3	4.3	0.83	96.4	91.3648	71.8391
2015	7	17	9	3	24	0.3	4.3	0.85	94.4	91.3648	74.1288
2015	7	17	9	13	24	0.3	4.3	0.85	96.4	91.3648	73.8426
2015	7	17	9	23	24	0.3	4.3	0.85	95.6	91.3648	73.5564
2015	7	17	9	33	24	0.3	4.3	0.86	98.3	91.3648	74.1288
2015	7	17	9	43	24	0.3	4.3	0.85	97.8	91.3648	73.5563
2015	7	17	9	53	24	0.3	4.3	0.83	96.6	91.3648	71.5528
2015	7	17	10	3	24	0.3	4.3	0.83	98.6	91.3648	71.839
2015	7	17	10	13	24	0.3	4.3	0.88	97.7	91.3648	75.8459
2015	7	17	10	23	24	0.3	4.3	0.8	97.8	91.3648	68.9769
2015	7	17	10	33	24	0.3	4.3	0.91	98.5	91.3648	78.1356
2015	7	17	10	43	24	0.3	4.3	0.83	94.8	91.3648	72.1251
2015	7	17	10	53	24	0.3	4.3	0.81	95.6	91.2992	70.3551
2015	7	17	11	3	24	0.3	4.3	0.81	97	91.2992	70.3551
2015	7	17	11	13	24	0.3	4.3	0.8	97.7	91.2992	69.4971
2015	7	17	11	23	24	0.3	4.3	0.83	96.4	91.2992	71.499
2015	7	17	11	33	24	0.3	4.3	0.83	96.6	91.2992	72.071
2015	7	17	11	43	24	0.3	4.3	0.84	96.5	91.2992	72.9289
2015	7	17	11	53	24	0.3	4.3	0.86	96.3	91.2992	74.9309
2015	7	17	12	3	24	0.3	4.3	0.83	95.4	91.2992	72.0709
2015	7	17	12	13	24	0.3	4.3	0.82	97.6	91.2992	70.9269
2015	7	17	12	23	24	0.3	4.3	0.79	98.4	91.2992	68.0669
2015	7	17	12	33	24	0.3	4.3	0.84	96.7	91.2336	72.5884
2015	7	17	12	43	24	0.3	4.3	0.85	97.5	91.2336	73.4457
2015	7	17	12	53	24	0.3	4.3	0.84	96.1	91.2336	72.5883
2015	7	17	13	3	24	0.3	4.3	0.85	98	91.2336	73.4456
2015	7	17	13	13	24	0.3	4.3	0.8	95	91.168	69.107
2015	7	17	13	23	24	0.3	4.3	0.79	98.3	91.168	68.2503
2015	7	17	13	33	24	0.3	4.3	0.81	97.5	91.1024	69.6258
2015	7	17	13	43	24	0.3	4.3	0.84	96.5	91.1024	72.4793
2015	7	17	13	53	24	0.3	4.3	0.79	96.7	91.0368	68.433
2015	7	17	14	3	24	0.3	4.3	0.8	97.6	91.0368	68.7181
2015	7	17	14	13	24	0.3	4.3	0.79	97.4	91.0368	68.1478
2015	7	17	14	23	24	0.3	4.3	0.79	96.7	90.9711	68.3815
2015	7	17	14	33	24	0.3	4.3	0.79	96.5	90.9711	67.8116
2015	7	17	14	43	24	0.3	4.3	0.8	96.6	90.9055	68.8994
2015	7	17	14	53	24	0.3	4.3	0.75	97.8	90.9055	64.0594
2015	7	17	15	3	24	0.3	4.3	0.82	94.3	90.9055	71.177
2015	7	17	15	13	24	0.3	4.3	0.81	96.8	90.9055	69.7535
2015	7	17	15	23	24	0.3	4.3	0.79	98.1	90.9055	68.0452

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	17	15	33	24	0.3	4.3	0.82	97.8	90.8399	70.27
2015	7	17	15	43	24	0.3	4.3	0.82	95.9	90.9055	71.177
2015	7	17	15	53	24	0.3	4.3	0.76	96.2	90.8399	65.4335
2015	7	17	16	3	24	0.3	4.3	0.78	97	90.7743	67.0899
2015	7	17	16	13	24	0.3	4.3	0.82	94.8	90.8399	70.8389
2015	7	17	16	23	24	0.3	4.3	0.79	95.2	90.7743	68.2271
2015	7	17	16	33	24	0.3	4.3	0.82	98.3	90.7743	70.217
2015	7	17	16	43	24	0.3	4.3	0.8	96.9	90.7743	68.5113
2015	7	17	16	53	24	0.3	4.3	0.83	96.4	90.7743	71.0698
2015	7	17	17	3	24	0.3	4.3	0.77	98.3	90.7743	66.2371
2015	7	17	17	13	24	0.3	4.3	0.81	95.6	90.7743	69.6484
2015	7	17	17	23	24	0.3	4.3	0.81	96.5	90.7087	69.3119
2015	7	17	17	33	24	0.3	4.3	0.78	96.3	90.7087	67.3234
2015	7	17	17	43	24	0.3	4.3	0.77	98.1	90.7087	65.9031
2015	7	17	17	53	24	0.3	4.3	0.76	96.7	90.7087	65.6191
2015	7	17	18	3	24	0.3	4.3	0.77	96.8	90.7087	66.4713
2015	7	17	18	13	24	0.3	4.3	0.81	96.8	90.7087	69.3119
2015	7	17	18	23	24	0.3	4.3	0.82	96.6	90.7087	70.7322
2015	7	17	18	33	24	0.3	4.3	0.77	96.6	90.7087	66.4713
2015	7	17	18	43	24	0.3	4.3	0.81	96.7	90.7087	69.8801
2015	7	17	18	53	24	0.3	4.3	0.78	98.9	90.7087	67.0394
2015	7	17	19	3	24	0.3	4.3	0.8	95.9	90.6431	69.2597
2015	7	17	19	13	24	0.3	4.3	0.83	96.6	90.6431	70.9628
2015	7	17	19	23	24	0.3	4.3	0.78	96.8	90.7087	66.7553
2015	7	17	19	33	24	0.3	4.3	0.79	96.9	90.6431	67.8404
2015	7	17	19	43	24	0.3	4.3	0.83	97.7	90.6431	71.2466
2015	7	17	19	53	24	0.3	4.3	0.78	94.8	90.6431	67.5566
2015	7	17	20	3	24	0.3	4.3	0.83	94.6	90.7087	71.3004
2015	7	17	20	13	24	0.3	4.3	0.86	95.1	90.6431	73.8013
2015	7	17	20	23	24	0.3	4.3	0.81	98.6	90.7087	69.3119
2015	7	17	20	33	24	0.3	4.3	0.85	97.7	90.7087	73.2889
2015	7	17	20	43	24	0.3	4.3	0.83	97.5	90.6431	70.9628
2015	7	17	20	53	24	0.3	4.3	0.79	94.5	90.7087	68.1757
2015	7	17	21	3	24	0.3	4.3	0.84	98.9	90.7087	72.1526
2015	7	17	21	13	24	0.3	4.3	0.8	96.3	90.7087	69.0279
2015	7	17	21	23	24	0.3	4.3	0.84	94.3	90.7087	72.1526
2015	7	17	21	33	24	0.3	4.3	0.81	96.3	90.6431	69.8274
2015	7	17	21	43	24	0.3	4.3	0.81	97	90.6431	69.2597
2015	7	17	21	53	24	0.3	4.3	0.82	95.5	90.6431	70.6789
2015	7	17	22	3	24	0.3	4.3	0.77	94.9	90.6431	66.705
2015	7	17	22	13	24	0.3	4.3	0.81	96.8	90.6431	69.2597
2015	7	17	22	23	24	0.3	4.3	0.83	98.5	90.6431	70.679
2015	7	17	22	33	24	0.3	4.3	0.8	95.7	90.7087	68.7439
2015	7	17	22	43	24	0.3	4.3	0.81	96.8	90.7087	69.312
2015	7	17	22	53	24	0.3	4.3	0.82	98.3	90.6431	70.1113
2015	7	17	23	3	24	0.3	4.3	0.8	94.2	90.7087	69.312
2015	7	17	23	13	24	0.3	4.3	0.79	94.5	90.7087	67.8917

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	17	23	23	24	0.3	4.3	0.83	95.7	90.7087	71.3005
2015	7	17	23	33	24	0.3	4.3	0.81	96.1	90.6431	69.2598
2015	7	17	23	43	24	0.3	4.3	0.8	98	90.6431	68.4082
2015	7	17	23	53	24	0.3	4.3	0.79	98.8	90.7087	67.6077
2015	7	18	0	3	24	0.3	4.3	0.81	98	90.7087	69.028
2015	7	18	0	13	24	0.3	4.3	0.75	97.8	90.6431	64.4343
2015	7	18	0	23	24	0.3	4.3	0.82	96.7	90.7087	70.1643
2015	7	18	0	33	24	0.3	4.3	0.79	96	90.6431	67.8406
2015	7	18	0	43	24	0.3	4.3	0.78	98.4	90.7087	67.0396
2015	7	18	0	53	24	0.3	4.3	0.8	100.4	90.7087	67.8918
2015	7	18	1	3	24	0.3	4.3	0.76	95.4	90.7087	65.6193
2015	7	18	1	13	24	0.3	4.3	0.79	97.2	90.7087	67.6077
2015	7	18	1	23	24	0.3	4.3	0.81	94.2	90.6431	69.5437
2015	7	18	1	33	24	0.3	4.3	0.85	96.4	90.7087	73.2891
2015	7	18	1	43	24	0.3	4.3	0.77	96.6	90.7087	66.4715
2015	7	18	1	53	24	0.3	4.3	0.81	95.6	90.7087	69.8803
2015	7	18	2	3	24	0.3	4.3	0.82	95.3	90.7087	70.7325
2015	7	18	2	13	24	0.3	4.3	0.79	98.1	90.7087	67.6078
2015	7	18	2	23	24	0.3	4.3	0.8	95.7	90.6431	68.6922
2015	7	18	2	33	24	0.3	4.3	0.78	93.6	90.6431	66.9891
2015	7	18	2	43	24	0.3	4.3	0.81	96.7	90.7087	69.8804
2015	7	18	2	53	24	0.3	4.3	0.82	96.2	90.7087	70.4485
2015	7	18	3	3	24	0.3	4.3	0.79	94.5	90.6431	67.8407
2015	7	18	3	13	24	0.3	4.3	0.81	99.3	90.6431	68.9761
2015	7	18	3	23	24	0.3	4.3	0.82	95.3	90.6431	70.6793
2015	7	18	3	33	24	0.3	4.3	0.79	95.7	90.6431	68.1246
2015	7	18	3	43	24	0.3	4.3	0.82	95.3	90.6431	70.9631
2015	7	18	3	53	24	0.3	4.3	0.82	95.8	90.6431	70.3954
2015	7	18	4	3	24	0.3	4.3	0.83	96.6	90.6431	70.9632
2015	7	18	4	13	24	0.3	4.3	0.81	97	90.6431	69.26
2015	7	18	4	23	24	0.3	4.3	0.81	97.9	90.6431	69.2601
2015	7	18	4	33	24	0.3	4.3	0.86	96.3	90.6431	74.3694
2015	7	18	4	43	24	0.3	4.3	0.83	95.2	90.6431	71.5309
2015	7	18	4	53	24	0.3	4.3	0.8	96.6	90.6431	68.6924
2015	7	18	5	3	24	0.3	4.3	0.86	96.4	90.6431	73.8018
2015	7	18	5	13	24	0.3	4.3	0.9	94.8	90.6431	77.208
2015	7	18	5	23	24	0.3	4.3	0.87	96.3	90.6431	74.6534
2015	7	18	5	33	24	0.3	4.3	0.81	97.9	90.6431	69.8279
2015	7	18	5	43	24	0.3	4.3	0.83	97.5	90.6431	71.2472
2015	7	18	5	53	24	0.3	4.3	0.85	96.4	90.6431	72.9503
2015	7	18	6	3	24	0.3	4.3	0.81	97.4	90.6431	69.828
2015	7	18	6	13	24	0.3	4.3	0.86	96.1	90.6431	73.8019
2015	7	18	6	23	24	0.3	4.3	0.83	95.4	90.6431	71.5311
2015	7	18	6	33	24	0.3	4.3	0.79	95.9	90.6431	68.4088
2015	7	18	6	43	24	0.3	4.3	0.85	97.5	90.6431	72.9505
2015	7	18	6	53	24	0.3	4.3	0.85	95.6	90.6431	72.9505
2015	7	18	7	3	24	0.3	4.3	0.83	98.6	90.6431	71.2474

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	18	7	13	24	0.3	4.3	0.78	96.5	90.6431	66.9896
2015	7	18	7	23	24	0.3	4.3	0.88	96.2	90.5774	75.4482
2015	7	18	7	33	24	0.3	4.3	0.83	97.1	90.5774	70.91
2015	7	18	7	43	24	0.3	4.3	0.8	96.8	90.5774	68.6409
2015	7	18	7	53	24	0.3	4.3	0.82	96.7	90.5774	70.3428
2015	7	18	8	3	24	0.3	4.3	0.85	96.5	90.5774	72.6119
2015	7	18	8	13	24	0.3	4.3	0.84	95.4	90.5774	72.6119
2015	7	18	8	23	24	0.3	4.3	0.83	97	90.5774	71.4773
2015	7	18	8	33	24	0.3	4.3	0.82	99	90.5774	69.7755
2015	7	18	8	43	24	0.3	4.3	0.8	94.5	90.5774	69.2082
2015	7	18	8	53	24	0.3	4.3	0.82	96.7	90.5774	70.0591
2015	7	18	9	3	24	0.3	4.3	0.82	93.7	90.5774	70.3427
2015	7	18	9	13	24	0.3	4.3	0.82	97.6	90.5774	70.0591
2015	7	18	9	23	24	0.3	4.3	0.84	94.3	90.5774	72.3282
2015	7	18	9	33	24	0.3	4.3	0.83	97.5	90.5774	71.4772
2015	7	18	9	43	24	0.3	4.3	0.8	96.8	90.5774	68.6408
2015	7	18	9	53	24	0.3	4.3	0.83	97.5	90.5774	71.1936
2015	7	18	10	3	24	0.3	4.3	0.79	96.7	90.5774	67.5062
2015	7	18	10	13	24	0.3	4.3	0.83	97.3	90.5774	71.1935
2015	7	18	10	23	24	0.3	4.3	0.81	98.4	90.5774	68.9244
2015	7	18	10	33	24	0.3	4.3	0.8	98.2	90.5774	68.6407
2015	7	18	10	43	24	0.3	4.3	0.82	96.2	90.5774	70.6262
2015	7	18	10	53	24	0.3	4.3	0.81	96.5	90.5774	69.4916
2015	7	18	11	3	24	0.3	4.3	0.81	98.6	90.5774	69.2079
2015	7	18	11	13	24	0.3	4.3	0.78	95.1	90.5774	67.2224
2015	7	18	11	23	24	0.3	4.3	0.78	96.5	90.5774	66.9387
2015	7	18	11	33	24	0.3	4.3	0.79	95.9	90.5774	68.3569
2015	7	18	11	43	24	0.3	4.3	0.8	97.3	90.5118	68.5887
2015	7	18	11	53	24	0.3	4.3	0.8	97.3	90.5118	68.8721
2015	7	18	12	3	24	0.3	4.3	0.83	98.4	90.5118	71.1394
2015	7	18	12	13	24	0.3	4.3	0.83	97.7	90.5118	71.1394
2015	7	18	12	23	24	0.3	4.3	0.82	94.4	90.5118	70.5725
2015	7	18	12	33	24	0.3	4.3	0.8	95.4	90.5118	68.8719
2015	7	18	12	43	24	0.3	4.3	0.78	96.3	90.5118	66.6045
2015	7	18	12	53	24	0.3	4.3	0.79	95.7	90.4462	67.687
2015	7	18	13	3	24	0.3	4.3	0.77	97.3	90.4462	66.2709
2015	7	18	13	13	24	0.3	4.3	0.82	97.8	90.3806	70.4657
2015	7	18	13	23	24	0.3	4.3	0.79	96.9	90.3806	67.6357
2015	7	18	13	33	24	0.3	4.3	0.75	95	90.315	64.7567
2015	7	18	13	43	24	0.3	4.3	0.75	93	90.315	64.474
2015	7	18	13	53	24	0.3	4.3	0.81	96.8	90.315	68.9985
2015	7	18	14	3	24	0.3	4.3	0.76	96.2	90.315	65.0396
2015	7	18	14	13	24	0.3	4.3	0.76	98.5	90.2494	64.4251
2015	7	18	14	23	24	0.3	4.3	0.74	96.4	90.2494	63.0123
2015	7	18	14	33	24	0.3	4.3	0.77	96.1	90.2494	65.838
2015	7	18	14	43	24	0.3	4.3	0.76	96	90.2494	64.7077
2015	7	18	14	53	24	0.3	4.3	0.74	96.6	90.315	63.6257

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	18	15	3	24	0.3	4.3	0.75	96.8	90.1181	63.7632
2015	7	18	15	13	24	0.3	4.3	0.76	96.4	90.2494	64.9902
2015	7	18	15	23	24	0.3	4.3	0.76	95.9	90.2494	65.2728
2015	7	18	15	33	24	0.3	4.3	0.79	97.8	90.2494	67.8159
2015	7	18	15	43	24	0.3	4.3	0.74	97.1	90.1837	63.5292
2015	7	18	15	53	24	0.3	4.3	0.76	96.2	90.1837	64.6586
2015	7	18	16	3	24	0.3	4.3	0.73	96.7	90.2494	62.1645
2015	7	18	16	13	24	0.3	4.3	0.76	96.5	90.2494	64.7076
2015	7	18	16	23	24	0.3	4.3	0.74	95.6	90.1837	62.9645
2015	7	18	16	33	24	0.3	4.3	0.79	97.9	90.1837	66.9174
2015	7	18	16	43	24	0.3	4.3	0.78	97.2	90.2494	66.9682
2015	7	18	16	53	24	0.3	4.3	0.75	97	90.2494	64.1426
2015	7	18	17	3	24	0.3	4.3	0.76	96.7	90.2494	65.2729
2015	7	18	17	13	24	0.3	4.3	0.74	97.9	90.2494	62.7298
2015	7	18	17	23	24	0.3	4.3	0.72	95.5	90.1837	61.8352
2015	7	18	17	33	24	0.3	4.3	0.78	96.1	90.2494	66.4031
2015	7	18	17	43	24	0.3	4.3	0.79	95.3	90.2494	67.5334
2015	7	18	17	53	24	0.3	4.3	0.8	94.7	90.315	68.9985
2015	7	18	18	3	24	0.3	4.3	0.79	97.8	90.2494	67.816
2015	7	18	18	13	24	0.3	4.3	0.77	95.9	90.315	65.888
2015	7	18	18	23	24	0.3	4.3	0.78	96.8	90.315	66.4535
2015	7	18	18	33	24	0.3	4.3	0.78	97.3	90.2494	66.4032
2015	7	18	18	43	24	0.3	4.3	0.78	99.5	90.315	65.888
2015	7	18	18	53	24	0.3	4.3	0.79	96.9	90.315	67.3019
2015	7	18	19	3	24	0.3	4.3	0.79	96.2	90.3806	67.6359
2015	7	18	19	13	24	0.3	4.3	0.81	95.6	90.3806	69.6168
2015	7	18	19	23	24	0.3	4.3	0.82	96.2	90.3806	70.1828
2015	7	18	19	33	24	0.3	4.3	0.78	98.4	90.3806	66.7869
2015	7	18	19	43	24	0.3	4.3	0.79	95.7	90.3806	67.9189
2015	7	18	19	53	24	0.3	4.3	0.79	95.9	90.4462	68.2535
2015	7	18	20	3	24	0.3	4.3	0.78	97.3	90.3806	66.5039
2015	7	18	20	13	24	0.3	4.3	0.8	95.6	90.4462	69.1032
2015	7	18	20	23	24	0.3	4.3	0.8	98.1	90.5118	68.0218
2015	7	18	20	33	24	0.3	4.3	0.75	97.7	90.4462	64.5718
2015	7	18	20	43	24	0.3	4.3	0.79	96.2	90.4462	67.404
2015	7	18	20	53	24	0.3	4.3	0.8	97.6	90.4462	68.2536
2015	7	18	21	3	24	0.3	4.3	0.81	97.5	90.5118	69.1555
2015	7	18	21	13	24	0.3	4.3	0.8	96.8	90.5118	68.8721
2015	7	18	21	23	24	0.3	4.3	0.78	98.2	90.5118	66.8881
2015	7	18	21	33	24	0.3	4.3	0.8	96.1	90.5774	68.9242
2015	7	18	21	43	24	0.3	4.3	0.8	98.9	90.5774	68.6405
2015	7	18	21	53	24	0.3	4.3	0.8	96.6	90.5774	68.9242
2015	7	18	22	3	24	0.3	4.3	0.78	95.8	90.5774	66.9387
2015	7	18	22	13	24	0.3	4.3	0.85	96	90.5774	73.1788
2015	7	18	22	23	24	0.3	4.3	0.84	97.2	90.5774	72.0442
2015	7	18	22	33	24	0.3	4.3	0.82	97.3	90.5774	70.626
2015	7	18	22	43	24	0.3	4.3	0.84	95.8	90.5774	72.3279

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	18	22	53	24	0.3	4.3	0.83	96.1	90.5774	71.1933
2015	7	18	23	3	24	0.3	4.3	0.82	95.5	90.6431	70.6794
2015	7	18	23	13	24	0.3	4.3	0.86	97.9	90.6431	73.8018
2015	7	18	23	23	24	0.3	4.3	0.86	95.5	90.6431	74.3695
2015	7	18	23	33	24	0.3	4.3	0.82	96.2	90.6431	70.6794
2015	7	18	23	43	24	0.3	4.3	0.79	96	90.6431	67.8409
2015	7	18	23	53	24	0.3	4.3	0.85	96.5	90.6431	72.6664
2015	7	19	0	3	24	0.3	4.3	0.87	94.5	90.6431	75.2211
2015	7	19	0	13	24	0.3	4.3	0.86	96.6	90.6431	74.0857
2015	7	19	0	23	24	0.3	4.3	0.8	97.3	90.7087	69.0284
2015	7	19	0	33	24	0.3	4.3	0.82	95.9	90.7087	71.0169
2015	7	19	0	43	24	0.3	4.3	0.83	97.5	90.7087	71.5851
2015	7	19	0	53	24	0.3	4.3	0.84	96.5	90.7087	71.8691
2015	7	19	1	3	24	0.3	4.3	0.83	97.9	90.7087	71.5851
2015	7	19	1	13	24	0.3	4.3	0.87	98.2	90.7087	74.7098
2015	7	19	1	23	24	0.3	4.3	0.86	95.5	90.7087	74.1417
2015	7	19	1	33	24	0.3	4.3	0.87	97.8	90.7087	74.4258
2015	7	19	1	43	24	0.3	4.3	0.82	95.9	90.7087	71.017
2015	7	19	1	53	24	0.3	4.3	0.85	94.4	90.7087	73.5736
2015	7	19	2	3	24	0.3	4.3	0.87	95.6	90.7087	74.7099
2015	7	19	2	13	24	0.3	4.3	0.83	96.1	90.7087	71.3011
2015	7	19	2	23	24	0.3	4.3	0.81	94.9	90.7743	69.6492
2015	7	19	2	33	24	0.3	4.3	0.85	96.5	90.7743	72.7763
2015	7	19	2	43	24	0.3	4.3	0.87	97.1	90.7743	75.0506
2015	7	19	2	53	24	0.3	4.3	0.81	97.4	90.7743	69.9335
2015	7	19	3	3	24	0.3	4.3	0.8	94.7	90.7743	69.365
2015	7	19	3	13	24	0.3	4.3	0.8	94.7	90.7743	69.365
2015	7	19	3	23	24	0.3	4.3	0.84	95.2	90.8399	72.5467
2015	7	19	3	33	24	0.3	4.3	0.83	96.1	90.8399	71.6933
2015	7	19	3	43	24	0.3	4.3	0.82	94.3	90.8399	71.1243
2015	7	19	3	53	24	0.3	4.3	0.8	96.9	90.9055	68.6154
2015	7	19	4	3	24	0.3	4.3	0.84	97.7	90.9055	72.032
2015	7	19	4	13	24	0.3	4.3	0.86	96.3	90.9711	74.6506
2015	7	19	4	23	24	0.3	4.3	0.82	96	90.9711	70.6616
2015	7	19	4	33	24	0.3	4.3	0.82	96.5	91.0368	70.4296
2015	7	19	4	43	24	0.3	4.3	0.84	97	91.0368	72.1405
2015	7	19	4	53	24	0.3	4.3	0.85	95.8	91.0368	73.5662
2015	7	19	5	3	24	0.3	4.3	0.82	98.7	91.0368	70.7148
2015	7	19	5	13	24	0.3	4.3	0.82	97.8	91.0368	71
2015	7	19	5	23	24	0.3	4.3	0.81	94.4	91.1024	70.1973
2015	7	19	5	33	24	0.3	4.3	0.78	97.2	91.1024	67.6291
2015	7	19	5	43	24	0.3	4.3	0.85	97.3	91.0368	72.996
2015	7	19	5	53	24	0.3	4.3	0.82	95	91.1024	71.0534
2015	7	19	6	3	24	0.3	4.3	0.81	98.6	91.1024	69.6266
2015	7	19	6	13	24	0.3	4.3	0.81	97.4	91.1024	70.1973
2015	7	19	6	23	24	0.3	4.3	0.89	95.3	91.1024	77.0459
2015	7	19	6	33	24	0.3	4.3	0.85	96.7	91.1024	73.3363

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	19	6	43	24	0.3	4.3	0.8	96.9	91.1024	68.7706
2015	7	19	6	53	24	0.3	4.3	0.83	97.7	91.1024	71.3388
2015	7	19	7	3	24	0.3	4.3	0.85	94.7	91.168	73.6769
2015	7	19	7	13	24	0.3	4.3	0.81	94.6	91.168	70.5357
2015	7	19	7	23	24	0.3	4.3	0.81	96.8	91.168	69.9645
2015	7	19	7	33	24	0.3	4.3	0.84	95.4	91.168	73.1058
2015	7	19	7	43	24	0.3	4.3	0.81	96	91.168	70.2501
2015	7	19	7	53	24	0.3	4.3	0.83	96.8	91.168	71.6779
2015	7	19	8	3	24	0.3	4.3	0.84	96.5	91.168	72.2491
2015	7	19	8	13	24	0.3	4.3	0.8	97.7	91.168	69.3934
2015	7	19	8	23	24	0.3	4.3	0.79	98.3	91.168	68.2511
2015	7	19	8	33	24	0.3	4.3	0.83	96.4	91.2336	71.7317
2015	7	19	8	43	24	0.3	4.3	0.83	96.6	91.2336	71.7317
2015	7	19	8	53	24	0.3	4.3	0.86	97.2	91.2336	74.3037
2015	7	19	9	3	24	0.3	4.3	0.83	95.2	91.2336	72.3032
2015	7	19	9	13	24	0.3	4.3	0.82	98.1	91.2336	70.5885
2015	7	19	9	23	24	0.3	4.3	0.84	95.6	91.2336	72.589
2015	7	19	9	33	24	0.3	4.3	0.85	95.3	91.2336	73.4463
2015	7	19	9	43	24	0.3	4.3	0.8	96.9	91.2336	68.8738
2015	7	19	9	53	24	0.3	4.3	0.83	99.5	91.2336	71.4458
2015	7	19	10	3	24	0.3	4.3	0.85	96	91.2992	73.5014
2015	7	19	10	13	24	0.3	4.3	0.82	98.1	91.2992	70.3553
2015	7	19	10	23	24	0.3	4.3	0.83	97.7	91.2992	71.7853
2015	7	19	10	33	24	0.3	4.3	0.82	97.3	91.2992	71.2133
2015	7	19	10	43	24	0.3	4.3	0.85	96.2	91.2992	73.7872
2015	7	19	10	53	24	0.3	4.3	0.82	98	91.2992	71.2132
2015	7	19	11	3	24	0.3	4.3	0.88	98.8	91.2992	76.0751
2015	7	19	11	13	24	0.3	4.3	0.82	97.8	91.2992	70.9272
2015	7	19	11	23	24	0.3	4.3	0.88	97.1	91.2992	75.7891
2015	7	19	11	33	24	0.3	4.3	0.79	95.2	91.2992	68.9251
2015	7	19	11	43	24	0.3	4.3	0.82	95.5	91.3648	70.9802
2015	7	19	11	53	24	0.3	4.3	0.84	95.8	91.3648	72.9837
2015	7	19	12	3	24	0.3	4.3	0.83	97.5	91.3648	71.8388
2015	7	19	12	13	24	0.3	4.3	0.86	98.6	91.3648	73.8422
2015	7	19	12	23	24	0.3	4.3	0.81	98.4	91.3648	69.549
2015	7	19	12	33	24	0.3	4.3	0.79	95.7	91.3648	68.9766
2015	7	19	12	43	24	0.3	4.3	0.84	97.7	91.3648	72.4111
2015	7	19	12	53	24	0.3	4.3	0.81	93.2	91.3648	70.6939
2015	7	19	13	3	24	0.3	4.3	0.77	96.6	91.3648	66.6869
2015	7	19	13	13	24	0.3	4.3	0.83	97.2	91.3648	72.1248
2015	7	19	13	23	24	0.3	4.3	0.83	97.7	91.4305	71.606
2015	7	19	13	33	24	0.3	4.3	0.82	97.5	91.4305	71.3195
2015	7	19	13	43	24	0.3	4.3	0.84	96.5	91.4305	72.4651
2015	7	19	13	53	24	0.3	4.3	0.82	96.2	91.4305	71.3194
2015	7	19	14	3	24	0.3	4.3	0.81	96.7	91.4305	70.4601
2015	7	19	14	13	24	0.3	4.3	0.8	98	91.4305	69.028
2015	7	19	14	23	24	0.3	4.3	0.83	96.1	91.4305	71.8922

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	19	14	33	24	0.3	4.3	0.82	95.5	91.4305	71.6057
2015	7	19	14	43	24	0.3	4.3	0.81	96.8	91.4305	69.8872
2015	7	19	14	53	24	0.3	4.3	0.84	96.5	91.4961	72.8058
2015	7	19	15	3	24	0.3	4.3	0.81	96	91.4961	70.7993
2015	7	19	15	13	24	0.3	4.3	0.84	94.9	91.4961	73.379
2015	7	19	15	23	24	0.3	4.3	0.8	96.8	91.4961	69.6527
2015	7	19	15	33	24	0.3	4.3	0.82	95.1	91.4961	71.0859
2015	7	19	15	43	24	0.3	4.3	0.77	98.4	91.4961	66.2131
2015	7	19	15	53	24	0.3	4.3	0.83	96.1	91.4961	71.9458
2015	7	19	16	3	24	0.3	4.3	0.79	95.9	91.4961	69.0794
2015	7	19	16	13	24	0.3	4.3	0.81	96.8	91.4961	69.9393
2015	7	19	16	23	24	0.3	4.3	0.81	97	91.4961	70.5126
2015	7	19	16	33	24	0.3	4.3	0.81	95.6	91.4961	70.5126
2015	7	19	16	43	24	0.3	4.3	0.81	95.6	91.5617	70.5653
2015	7	19	16	53	24	0.3	4.3	0.83	96.1	91.5617	71.9996
2015	7	19	17	3	24	0.3	4.3	0.8	97.5	91.5617	69.7048
2015	7	19	17	13	24	0.3	4.3	0.83	97.9	91.5617	71.9996
2015	7	19	17	23	24	0.3	4.3	0.85	98.6	91.4961	73.6656
2015	7	19	17	33	24	0.3	4.3	0.83	97	91.5617	72.2864
2015	7	19	17	43	24	0.3	4.3	0.82	95.7	91.5617	71.7127
2015	7	19	17	53	24	0.3	4.3	0.82	95.7	91.5617	71.7127
2015	7	19	18	3	24	0.3	4.3	0.8	96.8	91.5617	69.7048
2015	7	19	18	13	24	0.3	4.3	0.81	95.6	91.5617	70.2785
2015	7	19	18	23	24	0.3	4.3	0.85	96	91.5617	74.2944
2015	7	19	18	33	24	0.3	4.3	0.82	95.5	91.6273	71.7663
2015	7	19	18	43	24	0.3	4.3	0.85	95.7	91.6273	74.3499
2015	7	19	18	53	24	0.3	4.3	0.86	96.4	91.6273	74.6369
2015	7	19	19	3	24	0.3	4.3	0.87	95.6	91.6273	75.7852
2015	7	19	19	13	24	0.3	4.3	0.81	94.9	91.6273	70.3309
2015	7	19	19	23	24	0.3	4.3	0.94	94.2	91.6929	82.4492
2015	7	19	19	33	24	0.3	4.3	0.92	94.1	91.6929	80.7255
2015	7	19	19	43	24	0.3	4.3	0.94	94.6	91.8242	81.9968
2015	7	19	19	53	24	0.3	4.3	0.86	95.3	91.6929	74.9799
2015	7	19	20	3	24	0.3	4.3	0.84	95.4	91.7585	73.0234
2015	7	19	20	13	24	0.3	4.3	0.84	93.4	91.7585	73.5984
2015	7	19	20	23	24	0.3	4.3	0.82	98.3	91.7585	71.011
2015	7	19	20	33	24	0.3	4.3	0.86	94.4	91.8242	74.8041
2015	7	19	20	43	24	0.3	4.3	0.85	97.1	91.8242	74.2287
2015	7	19	20	53	24	0.3	4.3	0.84	95.2	91.9554	73.4749
2015	7	19	21	3	24	0.3	4.3	0.83	95	91.9554	72.8986
2015	7	19	21	13	24	0.3	4.3	0.86	94.4	92.021	74.9713
2015	7	19	21	23	24	0.3	4.3	0.84	95.4	92.021	73.8179
2015	7	19	21	33	24	0.3	4.3	0.86	91.1	92.0866	75.3156
2015	7	19	21	43	24	0.3	4.3	0.85	96.2	92.0866	74.7385
2015	7	19	21	53	24	0.3	4.3	0.89	94.7	92.0866	77.6241
2015	7	19	22	3	24	0.3	4.3	0.8	92.4	92.1522	70.1735
2015	7	19	22	13	24	0.3	4.3	0.87	96.3	92.1522	76.2379

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	19	22	23	24	0.3	4.3	0.85	96.2	92.1522	74.794
2015	7	19	22	33	24	0.3	4.3	0.83	95	92.1522	72.4838
2015	7	19	22	43	24	0.3	4.3	0.89	96.2	92.2179	77.7395
2015	7	19	22	53	24	0.3	4.3	0.82	94.8	92.2179	71.9596
2015	7	19	23	3	24	0.3	4.3	0.83	95.7	92.2179	72.5376
2015	7	19	23	13	24	0.3	4.3	0.8	94.5	92.2179	69.9366
2015	7	19	23	23	24	0.3	4.3	0.85	96.5	92.2179	73.9826
2015	7	19	23	33	24	0.3	4.3	0.82	96.7	92.2179	71.6706
2015	7	19	23	43	24	0.3	4.3	0.82	94.6	92.2179	72.2486
2015	7	19	23	53	24	0.3	4.3	0.8	95.6	92.2179	70.2256
2015	7	20	0	3	24	0.3	4.3	0.82	95.5	92.2179	72.2486
2015	7	20	0	13	24	0.3	4.3	0.84	97	92.2835	73.459
2015	7	20	0	23	24	0.3	4.3	0.85	95.8	92.2835	74.3267
2015	7	20	0	33	24	0.3	4.3	0.86	94.4	92.2835	75.1943
2015	7	20	0	43	24	0.3	4.3	0.82	94.6	92.2835	71.7238
2015	7	20	0	53	24	0.3	4.3	0.83	94.5	92.2835	73.1699
2015	7	20	1	3	24	0.3	4.3	0.87	96.2	92.4147	76.754
2015	7	20	1	13	24	0.3	4.3	0.86	91.1	92.4803	76.2311
2015	7	20	1	23	24	0.3	4.3	0.86	94	92.8084	75.6402
2015	7	20	1	33	24	0.3	4.3	0.86	93.3	92.874	76.5694
2015	7	20	1	43	24	0.3	4.3	0.9	93.3	92.9396	80.122
2015	7	20	1	53	24	0.3	4.3	0.84	93.1	93.0053	74.9327
2015	7	20	2	3	24	0.3	4.3	0.91	91.9	93.0053	80.4725
2015	7	20	2	13	24	0.3	4.3	0.83	91.1	93.0709	73.8207
2015	7	20	2	23	24	0.3	4.3	0.84	92.9	93.0709	74.4043
2015	7	20	2	33	24	0.3	4.3	0.89	92.7	93.1365	79.4229
2015	7	20	2	43	24	0.3	4.3	0.84	94.5	93.1365	74.751
2015	7	20	2	53	24	0.3	4.3	0.87	95.2	93.2021	76.8513
2015	7	20	3	3	24	0.3	4.3	0.89	94.2	93.2021	79.189
2015	7	20	3	13	24	0.3	4.3	0.9	93.4	93.3333	79.8905
2015	7	20	3	23	24	0.3	4.3	0.85	93.8	93.4646	75.6116
2015	7	20	3	33	24	0.3	4.3	0.88	96.2	93.5302	78.3064
2015	7	20	3	43	24	0.3	4.3	0.85	95.3	93.5302	75.6669
2015	7	20	3	53	24	0.3	4.3	0.85	96.9	93.5958	75.4287
2015	7	20	4	3	24	0.3	4.3	0.84	96.5	93.6614	74.6027
2015	7	20	4	13	24	0.3	4.3	0.83	95	93.6614	74.309
2015	7	20	4	23	24	0.3	4.3	0.87	97.6	93.727	77.5964
2015	7	20	4	33	24	0.3	4.3	0.8	93.8	93.727	71.7179
2015	7	20	4	43	24	0.3	4.3	0.84	97.7	93.727	74.3633
2015	7	20	4	53	24	0.3	4.3	0.82	97.8	93.727	73.1876
2015	7	20	5	3	24	0.3	4.3	0.86	98.4	93.7927	75.8882
2015	7	20	5	13	24	0.3	4.3	0.85	95.5	93.7927	75.8882
2015	7	20	5	23	24	0.3	4.3	0.84	95.6	93.8583	74.7661
2015	7	20	5	33	24	0.3	4.3	0.84	96.7	93.8583	74.7662
2015	7	20	5	43	24	0.3	4.3	0.88	97.3	93.8583	78.0041
2015	7	20	5	53	24	0.3	4.3	0.84	96.1	93.8583	74.7662
2015	7	20	6	3	24	0.3	4.3	0.83	95.7	93.9239	73.9369

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	20	6	13	24	0.3	4.3	0.85	96.4	93.9895	76.0542
2015	7	20	6	23	24	0.3	4.3	0.81	96.7	93.9895	72.5168
2015	7	20	6	33	24	0.3	4.3	0.87	96.9	94.0551	77.8796
2015	7	20	6	43	24	0.3	4.3	0.9	99	94.1864	79.7654
2015	7	20	6	53	24	0.3	4.3	0.86	95.7	94.252	76.8669
2015	7	20	7	3	24	0.3	4.3	0.86	95.7	94.3176	76.9226
2015	7	20	7	13	24	0.3	4.3	0.85	98.4	94.3176	76.0351
2015	7	20	7	23	24	0.3	4.3	0.88	94.3	94.3832	79.347
2015	7	20	7	33	24	0.3	4.3	0.85	96.9	94.3832	76.3863
2015	7	20	7	43	24	0.3	4.3	0.81	95.8	94.4488	72.8862
2015	7	20	7	53	24	0.3	4.3	0.82	96.6	94.4488	73.775
2015	7	20	8	3	24	0.3	4.3	0.84	98.1	94.4488	74.6639
2015	7	20	8	13	24	0.3	4.3	0.83	95.4	94.5144	74.7179
2015	7	20	8	23	24	0.3	4.3	0.88	94.9	94.5144	79.1654
2015	7	20	8	33	24	0.3	4.3	0.86	94.8	94.5144	77.3865
2015	7	20	8	43	24	0.3	4.3	0.8	95.7	94.58	71.8049
2015	7	20	8	53	24	0.3	4.3	0.84	96.8	94.58	75.0687
2015	7	20	9	3	24	0.3	4.3	0.82	97.5	94.6457	73.9353
2015	7	20	9	13	24	0.3	4.3	0.91	94.1	94.7113	82.0115
2015	7	20	9	23	24	0.3	4.3	0.91	96.4	94.7769	82.3681
2015	7	20	9	33	24	0.3	4.3	0.91	95.2	94.9738	82.2483
2015	7	20	9	43	24	0.3	4.3	0.87	92.2	95.0394	79.0272
2015	7	20	9	53	24	0.3	4.3	0.89	96.1	95.105	80.8746
2015	7	20	10	3	24	0.3	4.3	0.88	95.4	95.105	79.3824
2015	7	20	10	13	24	0.3	4.3	0.88	93.6	95.1706	80.3354
2015	7	20	10	23	24	0.3	4.3	0.9	94.6	95.2362	81.8874
2015	7	20	10	33	24	0.3	4.3	0.91	95.4	95.2362	82.784
2015	7	20	10	43	24	0.3	4.3	0.88	96	95.3018	80.1517
2015	7	20	10	53	24	0.3	4.3	0.85	94.7	95.3018	76.8619
2015	7	20	11	3	24	0.3	4.3	0.91	93.9	95.3018	82.5443
2015	7	20	11	13	24	0.3	4.3	0.9	94	95.3675	82.3042
2015	7	20	11	23	24	0.3	4.3	0.88	94.3	95.3675	80.5084
2015	7	20	11	33	24	0.3	4.3	0.86	94	95.4331	77.8706
2015	7	20	11	43	24	0.3	4.3	0.89	94	95.4331	81.1651
2015	7	20	11	53	24	0.3	4.3	0.87	96	95.4331	79.368
2015	7	20	12	3	24	0.3	4.3	0.87	95.4	95.4987	79.1252
2015	7	20	12	13	24	0.3	4.3	0.87	95.2	95.4987	78.8255
2015	7	20	12	23	24	0.3	4.3	0.85	95.7	95.5643	77.6821
2015	7	20	12	33	24	0.3	4.3	0.89	97	95.6299	81.0393
2015	7	20	12	43	24	0.3	4.3	0.83	98.9	95.6955	75.09
2015	7	20	12	53	24	0.3	4.3	0.87	96.2	95.8268	79.7091
2015	7	20	13	3	24	0.3	4.3	0.85	95.1	95.8924	77.9599
2015	7	20	13	13	24	0.3	4.3	0.88	96.4	95.8924	80.6689
2015	7	20	13	23	24	0.3	4.3	0.88	94.7	95.958	80.1239
2015	7	20	13	33	24	0.3	4.3	0.92	93.9	95.958	84.341
2015	7	20	13	43	24	0.3	4.3	0.87	94.5	96.0236	79.5781
2015	7	20	13	53	24	0.3	4.3	0.83	96.6	96.0236	75.6595

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	20	14	3	24	0.3	4.3	0.87	94.1	96.0236	79.2767
2015	7	20	14	13	24	0.3	4.3	0.83	96.4	96.0892	75.4117
2015	7	20	14	23	24	0.3	4.3	0.88	95.8	96.0892	80.238
2015	7	20	14	33	24	0.3	4.3	0.86	95.7	96.0892	78.4281
2015	7	20	14	43	24	0.3	4.3	0.86	95	96.0892	79.0314
2015	7	20	14	53	24	0.3	4.3	0.85	96.7	96.1549	77.2764
2015	7	20	15	3	24	0.3	4.3	0.85	96.9	96.0892	77.5232
2015	7	20	15	13	24	0.3	4.3	0.82	94.1	96.1549	75.1634
2015	7	20	15	23	24	0.3	4.3	0.87	95.6	96.1549	79.6913
2015	7	20	15	33	24	0.3	4.3	0.85	93.5	96.1549	78.1819
2015	7	20	15	43	24	0.3	4.3	0.84	95.4	96.1549	76.9745
2015	7	20	15	53	24	0.3	4.6	0.84	97.2	96.2205	76.7271
2015	7	20	16	3	24	0.3	4.6	0.91	94.7	96.2205	83.6748
2015	7	20	16	13	24	0.3	4.6	0.85	94.4	96.2205	77.9354
2015	7	20	16	23	24	0.3	4.6	0.85	97.5	96.2205	77.9353
2015	7	20	16	33	24	0.3	4.6	0.85	96.7	96.2205	77.3312
2015	7	20	16	43	24	0.3	4.6	0.86	96.6	96.2861	78.5953
2015	7	20	16	53	24	0.3	4.6	0.89	93.6	96.2861	81.6181
2015	7	20	17	3	24	0.3	4.6	0.85	97.7	96.2861	77.9907
2015	7	20	17	13	24	0.3	4.6	0.87	97.3	96.2861	79.8044
2015	7	20	17	23	24	0.3	4.6	0.88	94.7	96.2861	80.409
2015	7	20	17	33	24	0.3	4.6	0.86	95.3	96.3517	78.651
2015	7	20	17	43	24	0.3	4.6	0.88	96.6	96.3517	80.7685
2015	7	20	17	53	24	0.3	4.6	0.92	96.3	96.3517	84.701
2015	7	20	18	3	24	0.3	4.6	0.89	95.9	96.3517	81.3735
2015	7	20	18	13	24	0.3	4.6	0.89	95.1	96.3517	81.676
2015	7	20	18	23	24	0.3	4.6	0.86	95.9	96.3517	78.9535
2015	7	20	18	33	24	0.3	4.6	0.87	95.9	96.3517	79.5585
2015	7	20	18	43	24	0.3	4.6	0.89	95.5	96.4173	81.7339
2015	7	20	18	53	24	0.3	4.6	0.88	97.5	96.4173	80.5231
2015	7	20	19	3	24	0.3	4.6	0.91	94.8	96.4173	83.2475
2015	7	20	19	13	24	0.3	4.6	0.89	94.9	96.4173	81.7339
2015	7	20	19	23	24	0.3	4.6	0.86	95.2	96.4173	79.3122
2015	7	20	19	33	24	0.3	4.6	0.83	94.8	96.483	76.0362
2015	7	20	19	43	24	0.3	4.6	0.84	98.5	96.483	76.9449
2015	7	20	19	53	24	0.3	4.6	0.91	95.8	96.5486	83.6687
2015	7	20	20	3	24	0.3	4.6	0.87	94.3	96.5486	80.3341
2015	7	20	20	13	24	0.3	4.6	0.88	97.7	96.6142	80.9977
2015	7	20	20	23	24	0.3	4.6	0.89	96.2	96.6142	81.6044
2015	7	20	20	33	24	0.3	4.6	0.86	95.3	96.6798	78.9299
2015	7	20	20	43	24	0.3	4.6	0.86	96.1	96.6798	78.9299
2015	7	20	20	53	24	0.3	4.6	0.89	95.5	96.6798	81.9657
2015	7	20	21	3	24	0.3	4.6	0.91	94.8	96.6798	83.4836
2015	7	20	21	13	24	0.3	4.6	0.87	96.2	96.6798	80.4478
2015	7	20	21	23	24	0.3	4.6	0.83	93.4	96.7454	76.8592
2015	7	20	21	33	24	0.3	4.6	0.88	94.3	96.7454	80.8085
2015	7	20	21	43	24	0.3	4.6	0.86	95.9	96.7454	78.9857

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	20	21	53	24	0.3	4.6	0.9	94.6	96.7454	82.935
2015	7	20	22	3	24	0.3	4.6	0.85	95.7	96.7454	78.682
2015	7	20	22	13	24	0.3	4.6	0.87	95.9	96.7454	79.8971
2015	7	20	22	23	24	0.3	4.6	0.89	96.8	96.7454	81.7199
2015	7	20	22	33	24	0.3	4.6	0.86	97.5	96.7454	78.9858
2015	7	20	22	43	24	0.3	4.6	0.88	97	96.7454	81.1123
2015	7	20	22	53	24	0.3	4.6	0.91	95.4	96.7454	83.5427
2015	7	20	23	3	24	0.3	4.6	0.91	96.4	96.6798	84.0908
2015	7	20	23	13	24	0.3	4.6	0.9	95.9	96.7454	82.6313
2015	7	20	23	23	24	0.3	4.6	0.88	96	96.7454	81.1124
2015	7	20	23	33	24	0.3	4.6	0.87	95	96.6798	80.4479
2015	7	20	23	43	24	0.3	4.6	0.88	94.7	96.6798	81.3587
2015	7	20	23	53	24	0.3	4.6	0.9	94.4	96.6798	83.1801
2015	7	21	0	3	24	0.3	4.6	0.92	96.1	96.6798	84.6981
2015	7	21	0	13	24	0.3	4.6	0.92	94.5	96.6798	85.3052
2015	7	21	0	23	24	0.3	4.6	0.88	95.8	96.6798	81.3587
2015	7	21	0	33	24	0.3	4.6	0.89	95.1	96.6798	81.6623
2015	7	21	0	43	24	0.3	4.6	0.85	97.1	96.6798	78.323
2015	7	21	0	53	24	0.3	4.6	0.86	95.7	96.6798	78.9301
2015	7	21	1	3	24	0.3	4.6	0.88	94.7	96.6798	81.3588
2015	7	21	1	13	24	0.3	4.6	0.86	95.9	96.6142	79.1777
2015	7	21	1	23	24	0.3	4.6	0.83	95.2	96.6142	76.4475
2015	7	21	1	33	24	0.3	4.6	0.9	95	96.6142	83.1215
2015	7	21	1	43	24	0.3	4.6	0.85	96.6	96.6142	78.2677
2015	7	21	1	53	24	0.3	4.6	0.87	94.3	96.483	79.6717
2015	7	21	2	3	24	0.3	4.6	0.87	96.7	96.483	79.3687
2015	7	21	2	13	24	0.3	4.6	0.88	95.1	96.4173	80.8261
2015	7	21	2	23	24	0.3	4.6	0.85	95.5	96.4173	78.1017
2015	7	21	2	33	24	0.3	4.6	0.9	94.8	96.4173	82.9452
2015	7	21	2	43	24	0.3	4.6	0.89	95.1	96.3517	81.6764
2015	7	21	2	53	24	0.3	4.6	0.84	98	96.3517	77.1388
2015	7	21	3	3	24	0.3	4.6	0.87	95.4	96.3517	79.5589
2015	7	21	3	13	24	0.3	4.6	0.88	95.1	96.2861	80.7116
2015	7	21	3	23	24	0.3	4.6	0.92	97	96.2861	84.0368
2015	7	21	3	33	24	0.3	4.6	0.88	96.7	96.2861	80.1071
2015	7	21	3	43	24	0.3	4.6	0.86	95.7	96.2861	79.2002
2015	7	21	3	53	24	0.3	4.6	0.87	95.2	96.2861	79.5025
2015	7	21	4	3	24	0.3	4.6	0.87	97.2	96.2205	79.144
2015	7	21	4	13	24	0.3	4.6	0.86	94.6	96.2205	79.144
2015	7	21	4	23	24	0.3	4.6	0.91	96.6	96.2205	83.3731
2015	7	21	4	33	24	0.3	4.6	0.84	95.2	96.2205	77.0295
2015	7	21	4	43	24	0.3	4.6	0.93	94.3	96.2205	85.1856
2015	7	21	4	53	24	0.3	4.3	0.84	96.5	96.1549	76.9748
2015	7	21	5	3	24	0.3	4.3	0.9	96.3	96.1549	82.1065
2015	7	21	5	13	24	0.3	4.3	0.82	95.5	96.1549	74.8618
2015	7	21	5	23	24	0.3	4.3	0.83	95.7	96.0892	75.7136
2015	7	21	5	33	24	0.3	4.3	0.86	96.8	96.0892	78.4284

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	21	5	43	24	0.3	4.3	0.85	94.2	96.0892	77.5235
2015	7	21	5	53	24	0.3	4.3	0.88	95.2	96.0892	80.2383
2015	7	21	6	3	24	0.3	4.3	0.88	96	96.0892	80.54
2015	7	21	6	13	24	0.3	4.3	0.85	94.7	96.0236	77.7698
2015	7	21	6	23	24	0.3	4.3	0.87	96.3	96.0236	79.277
2015	7	21	6	33	24	0.3	4.3	0.89	92.9	96.0236	81.9899
2015	7	21	6	43	24	0.3	4.3	0.87	95.2	96.0236	79.5784
2015	7	21	6	53	24	0.3	4.3	0.86	94.4	96.0236	78.6742
2015	7	21	7	3	24	0.3	4.3	0.88	95.4	96.0236	80.1813
2015	7	21	7	13	24	0.3	4.3	0.86	95.2	95.958	78.9194
2015	7	21	7	23	24	0.3	4.3	0.89	98	95.958	81.0279
2015	7	21	7	33	24	0.3	4.3	0.84	97.6	95.958	76.8109
2015	7	21	7	43	24	0.3	4.3	0.82	94.1	95.958	75.3048
2015	7	21	7	53	24	0.3	4.3	0.87	94.1	95.8924	79.1642
2015	7	21	8	3	24	0.3	4.3	0.86	96.4	95.8924	77.9602
2015	7	21	8	13	24	0.3	4.3	0.82	95.5	95.8924	75.2512
2015	7	21	8	23	24	0.3	4.3	0.88	94.9	95.8268	80.6117
2015	7	21	8	33	24	0.3	4.3	0.86	97.5	95.8268	78.2054
2015	7	21	8	43	24	0.3	4.3	0.9	97.1	95.7612	81.7565
2015	7	21	8	53	24	0.3	4.3	0.9	95.6	95.6955	82.2989
2015	7	21	9	3	24	0.3	4.3	0.86	96.3	95.6299	78.3382
2015	7	21	9	13	24	0.3	4.3	0.84	95.4	95.4987	76.7276
2015	7	21	9	23	24	0.3	4.3	0.88	96.2	95.4987	79.7248
2015	7	21	9	33	24	0.3	4.3	0.87	95.2	95.4331	78.7692
2015	7	21	9	43	24	0.3	4.3	0.86	97.5	95.4331	77.5712
2015	7	21	9	53	24	0.3	4.3	0.85	94.9	95.4331	77.5712
2015	7	21	10	3	24	0.3	4.3	0.86	97.5	95.4331	77.5711
2015	7	21	10	13	24	0.3	4.3	0.83	93.9	95.3675	75.1213
2015	7	21	10	23	24	0.3	4.3	0.84	94.5	95.3675	76.0191
2015	7	21	10	33	24	0.3	4.3	0.81	95.6	95.3675	73.3255
2015	7	21	10	43	24	0.3	4.3	0.81	96.3	95.3675	73.6247
2015	7	21	10	53	24	0.3	4.3	0.85	94.7	95.3018	76.8617
2015	7	21	11	3	24	0.3	4.3	0.85	97.6	95.3018	76.5627
2015	7	21	11	13	24	0.3	4.3	0.87	96	95.3018	79.2543
2015	7	21	11	23	24	0.3	4.3	0.86	97.5	95.3018	77.4598
2015	7	21	11	33	24	0.3	4.3	0.87	96.1	95.3018	78.9551
2015	7	21	11	43	24	0.3	4.3	0.86	96.6	95.2362	78.0019
2015	7	21	11	53	24	0.3	4.3	0.85	94.2	95.2362	77.4042
2015	7	21	12	3	24	0.3	4.3	0.82	95.7	95.2362	74.7144
2015	7	21	12	13	24	0.3	4.3	0.85	94.4	95.1706	77.0499
2015	7	21	12	23	24	0.3	4.3	0.86	95.7	95.1706	78.2444
2015	7	21	12	33	24	0.3	4.3	0.84	97.2	95.105	75.5024
2015	7	21	12	43	24	0.3	4.3	0.83	97.1	95.0394	74.5534
2015	7	21	12	53	24	0.3	4.3	0.8	96.8	94.9081	72.0639
2015	7	21	13	3	24	0.3	4.3	0.88	94.9	94.9081	79.5084
2015	7	21	13	13	24	0.3	4.3	0.86	96.6	94.8425	77.3681
2015	7	21	13	23	24	0.3	4.3	0.82	96.2	94.8425	73.7973

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	21	13	33	24	0.3	4.3	0.86	95	94.7769	77.6097
2015	7	21	13	43	24	0.3	4.3	0.87	96.9	94.7769	78.2044
2015	7	21	13	53	24	0.3	4.3	0.83	95.9	94.7113	74.8794
2015	7	21	14	3	24	0.3	4.3	0.84	97.2	94.7113	75.7708
2015	7	21	14	13	24	0.3	4.3	0.86	94.8	94.7113	77.2564
2015	7	21	14	23	24	0.3	4.3	0.88	96.9	94.7113	79.0392
2015	7	21	14	33	24	0.3	4.3	0.82	95.7	94.7113	74.285
2015	7	21	14	43	24	0.3	4.3	0.85	98.9	94.6457	76.0129
2015	7	21	14	53	24	0.3	4.3	0.85	94.4	94.6457	76.6067
2015	7	21	15	3	24	0.3	4.3	0.82	95.8	94.6457	73.6375
2015	7	21	15	13	24	0.3	4.3	0.8	99.4	94.6457	71.559
2015	7	21	15	23	24	0.3	4.3	0.83	96.8	94.58	74.1776
2015	7	21	15	33	24	0.3	4.3	0.81	95.8	94.58	73.2875
2015	7	21	15	43	24	0.3	4.3	0.78	96.3	94.5144	70.2695
2015	7	21	15	53	24	0.3	4.3	0.86	95.7	94.5144	77.3854
2015	7	21	16	3	24	0.3	4.3	0.84	96.2	94.4488	75.848
2015	7	21	16	13	24	0.3	4.3	0.84	97.6	94.4488	75.2555
2015	7	21	16	23	24	0.3	4.3	0.83	95.7	94.3832	74.6089
2015	7	21	16	33	24	0.3	4.3	0.83	96.6	94.3176	73.9631
2015	7	21	16	43	24	0.3	4.3	0.83	96.3	94.252	74.5008
2015	7	21	16	53	24	0.3	4.3	0.79	95.5	94.1864	71.1971
2015	7	21	17	3	24	0.3	4.3	0.82	96.2	94.1207	73.2119
2015	7	21	17	13	24	0.3	4.3	0.88	96.2	94.1207	78.5256
2015	7	21	17	23	24	0.3	4.3	0.87	95.4	94.1207	77.64
2015	7	21	17	33	24	0.3	4.3	0.8	95.9	94.1207	71.7358
2015	7	21	17	43	24	0.3	4.3	0.83	96.8	94.1207	73.8023
2015	7	21	17	53	24	0.3	4.3	0.81	96.5	94.1207	72.031
2015	7	21	18	3	24	0.3	4.3	0.82	96.4	94.0551	73.4537
2015	7	21	18	13	24	0.3	4.3	0.81	97.7	94.0551	71.9787
2015	7	21	18	23	24	0.3	4.3	0.83	96.6	94.0551	74.0437
2015	7	21	18	33	24	0.3	4.3	0.81	95.8	94.0551	72.2737
2015	7	21	18	43	24	0.3	4.3	0.83	97.3	93.9895	73.695
2015	7	21	18	53	24	0.3	4.3	0.81	96.3	93.9895	72.2211
2015	7	21	19	3	24	0.3	4.3	0.83	96.8	93.9895	73.6951
2015	7	21	19	13	24	0.3	4.3	0.82	97.4	93.9895	73.1055
2015	7	21	19	23	24	0.3	4.3	0.82	96.7	93.9239	72.7578
2015	7	21	19	33	24	0.3	4.3	0.78	95.1	93.9895	69.8629
2015	7	21	19	43	24	0.3	4.3	0.86	96.4	93.9895	76.3481
2015	7	21	19	53	24	0.3	4.3	0.83	95.4	93.9239	74.5252
2015	7	21	20	3	24	0.3	4.3	0.85	95.5	93.9239	75.998
2015	7	21	20	13	24	0.3	4.3	0.83	94.8	93.9239	74.2306
2015	7	21	20	23	24	0.3	4.3	0.84	93.6	93.9239	75.4089
2015	7	21	20	33	24	0.3	4.3	0.85	95.1	93.9239	76.2926
2015	7	21	20	43	24	0.3	4.3	0.8	97.5	93.9239	71.5795
2015	7	21	20	53	24	0.3	4.3	0.82	96.4	93.9239	73.3469
2015	7	21	21	3	24	0.3	4.3	0.87	94.1	93.9239	78.3545
2015	7	21	21	13	24	0.3	4.3	0.86	95.7	93.8583	76.8258

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	21	21	23	24	0.3	4.3	0.85	94.7	93.8583	75.6484
2015	7	21	21	33	24	0.3	4.3	0.87	96.7	93.8583	77.1201
2015	7	21	21	43	24	0.3	4.3	0.85	94.7	93.8583	75.6484
2015	7	21	21	53	24	0.3	4.3	0.84	97.2	93.8583	75.0597
2015	7	21	22	3	24	0.3	4.3	0.84	94.2	93.8583	75.3541
2015	7	21	22	13	24	0.3	4.3	0.81	94.4	93.8583	72.1162
2015	7	21	22	23	24	0.3	4.3	0.88	96.9	93.7927	78.2405
2015	7	21	22	33	24	0.3	4.3	0.83	96.1	93.7927	74.4168
2015	7	21	22	43	24	0.3	4.3	0.87	97.2	93.7927	77.064
2015	7	21	22	53	24	0.3	4.3	0.88	96.9	93.7927	77.9464
2015	7	21	23	3	24	0.3	4.3	0.79	92.6	93.7927	71.1813
2015	7	21	23	13	24	0.3	4.3	0.86	94.4	93.7927	76.4758
2015	7	21	23	23	24	0.3	4.3	0.87	95.2	93.727	77.5957
2015	7	21	23	33	24	0.3	4.3	0.87	96.7	93.727	77.5958
2015	7	21	23	43	24	0.3	4.3	0.84	94.5	93.727	75.2444
2015	7	21	23	53	24	0.3	4.3	0.87	96.9	93.727	77.3019
2015	7	22	0	3	24	0.3	4.3	0.87	96.7	93.727	77.0079
2015	7	22	0	13	24	0.3	4.3	0.88	95.4	93.727	78.1836
2015	7	22	0	23	24	0.3	4.3	0.86	93.1	93.6614	76.6581
2015	7	22	0	33	24	0.3	4.3	0.82	95	93.6614	73.4273
2015	7	22	0	43	24	0.3	4.3	0.86	95.5	93.6614	76.6581
2015	7	22	0	53	24	0.3	4.3	0.83	96.1	93.6614	74.3085
2015	7	22	1	3	24	0.3	4.3	0.85	94	93.6614	75.4833
2015	7	22	1	13	24	0.3	4.3	0.83	95.5	93.6614	73.7211
2015	7	22	1	23	24	0.3	4.3	0.86	95	93.5958	76.6022
2015	7	22	1	33	24	0.3	4.3	0.87	97.3	93.5958	77.4827
2015	7	22	1	43	24	0.3	4.3	0.83	97.7	93.5958	73.3738
2015	7	22	1	53	24	0.3	4.3	0.86	96.8	93.5302	76.253
2015	7	22	2	3	24	0.3	4.3	0.83	95.5	93.4646	73.5597
2015	7	22	2	13	24	0.3	4.3	0.85	98.5	93.3989	74.6773
2015	7	22	2	23	24	0.3	4.3	0.84	94.9	93.3989	74.9701
2015	7	22	2	33	24	0.3	4.3	0.85	95.3	93.3333	75.5006
2015	7	22	2	43	24	0.3	4.3	0.84	95.4	93.3333	74.33
2015	7	22	2	53	24	0.3	4.3	0.89	95.9	93.3333	79.0122
2015	7	22	3	3	24	0.3	4.3	0.88	97.7	93.2677	77.4922
2015	7	22	3	13	24	0.3	4.3	0.83	97.1	93.2677	73.1059
2015	7	22	3	23	24	0.3	4.3	0.87	96	93.2677	77.4923
2015	7	22	3	33	24	0.3	4.3	0.87	95.8	93.2677	77.1999
2015	7	22	3	43	24	0.3	4.3	0.8	96.8	93.2677	71.059
2015	7	22	3	53	24	0.3	4.3	0.83	95.6	93.2021	73.929
2015	7	22	4	3	24	0.3	4.3	0.81	96.8	93.2021	71.5913
2015	7	22	4	13	24	0.3	4.3	0.88	96.4	93.2021	78.3122
2015	7	22	4	23	24	0.3	4.3	0.8	95.6	93.2021	71.2992
2015	7	22	4	33	24	0.3	4.3	0.88	95.2	93.2021	77.7278
2015	7	22	4	43	24	0.3	4.3	0.84	95.4	93.1365	74.1668
2015	7	22	4	53	24	0.3	4.3	0.85	100	93.1365	74.7508
2015	7	22	5	3	24	0.3	4.3	0.85	95.3	93.1365	75.3348

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	22	5	13	24	0.3	4.3	0.85	96.2	93.1365	75.6269
2015	7	22	5	23	24	0.3	4.3	0.81	93	93.1365	72.1229
2015	7	22	5	33	24	0.3	4.3	0.85	95.3	93.0709	74.9878
2015	7	22	5	43	24	0.3	4.3	0.84	95.4	93.0709	74.1125
2015	7	22	5	53	24	0.3	4.3	0.82	94.4	93.0709	72.6536
2015	7	22	6	3	24	0.3	4.3	0.84	97.2	93.0709	73.8207
2015	7	22	6	13	24	0.3	4.3	0.82	94.1	93.0709	72.9454
2015	7	22	6	23	24	0.3	4.3	0.83	97.7	93.0053	72.8918
2015	7	22	6	33	24	0.3	4.3	0.82	96.9	93.0053	72.6003
2015	7	22	6	43	24	0.3	4.3	0.78	96.7	93.0053	69.1015
2015	7	22	6	53	24	0.3	4.3	0.82	95.1	93.0053	72.3088
2015	7	22	7	3	24	0.3	4.3	0.81	96.3	93.0053	71.1425
2015	7	22	7	13	24	0.3	4.3	0.84	96.9	92.9396	74.2951
2015	7	22	7	23	24	0.3	4.3	0.85	96.9	92.9396	75.1692
2015	7	22	7	33	24	0.3	4.3	0.82	95.7	92.9396	72.547
2015	7	22	7	43	24	0.3	4.3	0.8	95.4	92.9396	70.5075
2015	7	22	7	53	24	0.3	4.3	0.83	97.7	92.9396	72.8383
2015	7	22	8	3	24	0.3	4.3	0.86	95.5	92.9396	76.0432
2015	7	22	8	13	24	0.3	4.3	0.85	98.4	92.9396	74.8778
2015	7	22	8	23	24	0.3	4.3	0.84	97.6	92.874	73.9493
2015	7	22	8	33	24	0.3	4.3	0.82	93.9	92.874	72.4936
2015	7	22	8	43	24	0.3	4.3	0.86	97.9	92.874	75.6961
2015	7	22	8	53	24	0.3	4.3	0.83	97.5	92.8084	72.7311
2015	7	22	9	3	24	0.3	4.3	0.84	97.7	92.8084	73.6039
2015	7	22	9	13	24	0.3	4.3	0.83	96.1	92.8084	73.6039
2015	7	22	9	23	24	0.3	4.3	0.82	95.5	92.7428	72.3868
2015	7	22	9	33	24	0.3	4.3	0.84	97.6	92.7428	74.131
2015	7	22	9	43	24	0.3	4.3	0.85	96.5	92.6772	74.3668
2015	7	22	9	53	24	0.3	4.3	0.84	95.2	92.6116	73.7314
2015	7	22	10	3	24	0.3	4.3	0.84	98.5	92.4803	73.3326
2015	7	22	10	13	24	0.3	4.3	0.84	95.8	92.4803	73.9123
2015	7	22	10	23	24	0.3	4.3	0.83	97	92.4147	72.9887
2015	7	22	10	33	24	0.3	4.3	0.82	96.7	92.4147	71.8301
2015	7	22	10	43	24	0.3	4.3	0.8	95.2	92.3491	70.6192
2015	7	22	10	53	24	0.3	4.3	0.84	97	92.3491	73.5135
2015	7	22	11	3	24	0.3	4.3	0.81	95.6	92.3491	70.9086
2015	7	22	11	13	24	0.3	4.3	0.8	97.3	92.2835	69.9885
2015	7	22	11	23	24	0.3	4.3	0.81	98.8	92.2835	70.8561
2015	7	22	11	33	24	0.3	4.3	0.82	96.6	92.2835	72.0129
2015	7	22	11	43	24	0.3	4.3	0.79	95.9	92.2835	69.6992
2015	7	22	11	53	24	0.3	4.3	0.84	97.6	92.2179	73.6934
2015	7	22	12	3	24	0.3	4.3	0.78	97	92.2179	68.2025
2015	7	22	12	13	24	0.3	4.3	0.81	96.7	92.1522	71.0397
2015	7	22	12	23	24	0.3	4.3	0.78	98.2	92.1522	67.8631
2015	7	22	12	33	24	0.3	4.3	0.78	97	92.0866	68.1012
2015	7	22	12	43	24	0.3	4.3	0.78	97	92.021	67.7623
2015	7	22	12	53	24	0.3	4.3	0.76	97.5	92.021	66.0322

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	22	13	3	24	0.3	4.3	0.78	95.5	91.9554	68.2881
2015	7	22	13	13	24	0.3	4.3	0.76	97.5	91.8898	65.934
2015	7	22	13	23	24	0.3	4.3	0.76	94.4	91.8242	66.748
2015	7	22	13	33	24	0.3	4.3	0.82	98.1	91.7585	70.7231
2015	7	22	13	43	24	0.3	4.3	0.77	100.3	91.7585	66.1233
2015	7	22	13	53	24	0.3	4.3	0.79	97.2	91.7585	68.7107
2015	7	22	14	3	24	0.3	4.3	0.75	95.3	91.6929	65.2121
2015	7	22	14	13	24	0.3	4.3	0.75	97.1	91.6273	64.8764
2015	7	22	14	23	24	0.3	4.3	0.83	97	91.6273	72.0529
2015	7	22	14	33	24	0.3	4.3	0.79	97.2	91.6273	68.3211
2015	7	22	14	43	24	0.3	4.3	0.77	97.3	91.5617	67.1227
2015	7	22	14	53	24	0.3	4.3	0.78	97	91.5617	67.6963
2015	7	22	15	3	24	0.3	4.3	0.8	96.4	91.4961	69.3656
2015	7	22	15	13	24	0.3	4.3	0.78	95.8	91.4961	67.3591
2015	7	22	15	23	24	0.3	4.3	0.76	95.7	91.4305	66.4494
2015	7	22	15	33	24	0.3	4.3	0.76	97.2	91.4305	66.163
2015	7	22	15	43	24	0.3	4.3	0.79	94.5	91.3648	68.9756
2015	7	22	15	53	24	0.3	4.3	0.76	97.2	91.3648	65.8273
2015	7	22	16	3	24	0.3	4.3	0.75	96.5	91.2336	64.8714
2015	7	22	16	13	24	0.3	4.3	0.81	96.5	91.168	70.2485
2015	7	22	16	23	24	0.3	4.3	0.79	96.7	91.168	68.2495
2015	7	22	16	33	24	0.3	4.3	0.78	98	91.1024	67.3423
2015	7	22	16	43	24	0.3	4.3	0.76	97.4	91.0368	65.5809
2015	7	22	16	53	24	0.3	4.3	0.8	98.5	90.9711	68.6657
2015	7	22	17	3	24	0.3	4.3	0.77	97.1	90.9711	66.3864
2015	7	22	17	13	24	0.3	4.3	0.79	98.4	90.9055	67.76
2015	7	22	17	23	24	0.3	4.3	0.78	97.2	90.9055	67.1906
2015	7	22	17	33	24	0.3	4.3	0.8	96.6	90.8399	68.5625
2015	7	22	17	43	24	0.3	4.3	0.76	98.2	90.8399	65.1486
2015	7	22	17	53	24	0.3	4.3	0.78	95.8	90.8399	67.4245
2015	7	22	18	3	24	0.3	4.3	0.73	100.1	90.7743	62.541
2015	7	22	18	13	24	0.3	4.3	0.81	98.1	90.8399	69.7004
2015	7	22	18	23	24	0.3	4.3	0.78	97.3	90.7743	66.8052
2015	7	22	18	33	24	0.3	4.3	0.81	97.6	90.7743	69.9322
2015	7	22	18	43	24	0.3	4.3	0.79	97.9	90.7087	67.323
2015	7	22	18	53	24	0.3	4.3	0.83	97.3	90.7087	71.0158
2015	7	22	19	3	24	0.3	4.3	0.83	98.2	90.7087	70.7317
2015	7	22	19	13	24	0.3	4.3	0.78	96.3	90.6431	67.2722
2015	7	22	19	23	24	0.3	4.3	0.81	97.2	90.6431	69.2591
2015	7	22	19	33	24	0.3	4.3	0.75	97.8	90.5774	64.1014
2015	7	22	19	43	24	0.3	4.3	0.81	98.6	90.6431	69.543
2015	7	22	19	53	24	0.3	4.3	0.81	97.9	90.5774	69.7741
2015	7	22	20	3	24	0.3	4.3	0.83	96.8	90.4462	71.368
2015	7	22	20	13	24	0.3	4.3	0.81	97	90.4462	69.6687
2015	7	22	20	23	24	0.3	4.3	0.81	95.8	90.4462	69.6687
2015	7	22	20	33	24	0.3	4.3	0.78	96.5	90.3806	66.7861
2015	7	22	20	43	24	0.3	4.3	0.79	96.9	90.2494	67.8152

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	22	20	53	24	0.3	4.3	0.83	100.2	90.2494	70.3583
2015	7	22	21	3	24	0.3	4.3	0.75	97.3	90.1837	64.0933
2015	7	22	21	13	24	0.3	4.3	0.79	97.4	90.1837	67.4815
2015	7	22	21	23	24	0.3	4.3	0.78	97	90.1837	66.3521
2015	7	22	21	33	24	0.3	4.3	0.83	97.7	90.1837	70.8697
2015	7	22	21	43	24	0.3	4.3	0.79	95.9	90.1181	67.9946
2015	7	22	21	53	24	0.3	4.3	0.8	97.8	90.1181	67.9946
2015	7	22	22	3	24	0.3	4.3	0.81	96.7	90.1181	69.4053
2015	7	22	22	13	24	0.3	4.3	0.81	96.7	90.1181	69.4053
2015	7	22	22	23	24	0.3	4.3	0.82	97.2	90.0525	69.6345
2015	7	22	22	33	24	0.3	4.3	0.8	95.6	90.0525	68.5068
2015	7	22	22	43	24	0.3	4.3	0.8	95.7	90.0525	68.2249
2015	7	22	22	53	24	0.3	4.3	0.76	97.5	89.9869	64.5109
2015	7	22	23	3	24	0.3	4.3	0.79	98.3	89.9869	67.328
2015	7	22	23	13	24	0.3	4.3	0.75	96.1	89.9869	63.6658
2015	7	22	23	23	24	0.3	4.3	0.81	97.2	89.9869	69.2999
2015	7	22	23	33	24	0.3	4.3	0.8	95.6	89.9869	68.7365
2015	7	22	23	43	24	0.3	4.3	0.81	96.8	89.9869	69.0182
2015	7	22	23	53	24	0.3	4.3	0.81	94.9	89.9869	69.5817
2015	7	23	0	3	24	0.3	4.3	0.8	98.2	89.9213	68.1213
2015	7	23	0	13	24	0.3	4.3	0.75	96.5	89.9213	63.8989
2015	7	23	0	23	24	0.3	4.3	0.78	98.4	89.9213	66.4324
2015	7	23	0	33	24	0.3	4.3	0.79	95.9	89.9213	67.5583
2015	7	23	0	43	24	0.3	4.3	0.8	95.9	89.8556	68.3508
2015	7	23	0	53	24	0.3	4.3	0.81	96.7	89.8556	69.1946
2015	7	23	1	3	24	0.3	4.3	0.76	97.4	89.8556	64.6942
2015	7	23	1	13	24	0.3	4.3	0.78	96.1	89.8556	66.1006
2015	7	23	1	23	24	0.3	4.3	0.78	96.8	89.79	66.0503
2015	7	23	1	33	24	0.3	4.3	0.81	95.8	89.79	69.142
2015	7	23	1	43	24	0.3	4.3	0.81	96.8	89.79	68.8609
2015	7	23	1	53	24	0.3	4.3	0.8	97.3	89.7244	67.9659
2015	7	23	2	3	24	0.3	4.3	0.82	94.8	89.7244	69.9318
2015	7	23	2	13	24	0.3	4.3	0.78	95.3	89.7244	66.8425
2015	7	23	2	23	24	0.3	4.3	0.82	96.5	89.6588	69.3173
2015	7	23	2	33	24	0.3	3.9	0.83	96.6	89.5932	70.3861
2015	7	23	2	43	24	0.3	3.9	0.82	96.6	89.5276	69.7719
2015	7	23	2	53	24	0.3	3.9	0.81	97.9	89.462	68.8786
2015	7	23	3	3	24	0.3	3.9	0.81	97.4	89.462	68.8786
2015	7	23	3	13	24	0.3	3.9	0.82	96	89.3963	69.6653
2015	7	23	3	23	24	0.3	3.9	0.78	95.8	89.3963	66.3079
2015	7	23	3	33	24	0.3	3.9	0.82	97.5	89.3963	69.6653
2015	7	23	3	43	24	0.3	3.9	0.82	95.5	89.3307	69.8916
2015	7	23	3	53	24	0.3	3.9	0.82	94.4	89.3307	69.3324
2015	7	23	4	3	24	0.3	3.9	0.79	97.2	89.3307	66.8164
2015	7	23	4	13	24	0.3	3.9	0.84	94.2	89.3307	71.569
2015	7	23	4	23	24	0.3	3.9	0.79	95.7	89.3307	67.096
2015	7	23	4	33	24	0.3	3.9	0.82	93.7	89.2651	69.8381

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	23	4	43	24	0.3	3.9	0.85	96	89.2651	72.0729
2015	7	23	4	53	24	0.3	3.9	0.81	98	89.2651	67.8827
2015	7	23	5	3	24	0.3	3.9	0.81	94.7	89.2651	68.4414
2015	7	23	5	13	24	0.3	3.9	0.79	96.5	89.2651	66.4859
2015	7	23	5	23	24	0.3	3.9	0.82	93.9	89.1995	69.2263
2015	7	23	5	33	24	0.3	3.9	0.79	95	89.1995	66.9932
2015	7	23	5	43	24	0.3	3.9	0.79	93.6	89.1995	66.7141
2015	7	23	5	53	24	0.3	3.9	0.77	95.9	89.1995	65.3184
2015	7	23	6	3	24	0.3	3.9	0.79	95.5	89.1995	66.9933
2015	7	23	6	13	24	0.3	3.9	0.82	97.2	89.1995	68.9473
2015	7	23	6	23	24	0.3	3.9	0.81	94.2	89.1339	68.8944
2015	7	23	6	33	24	0.3	3.9	0.78	95.8	89.1339	65.8262
2015	7	23	6	43	24	0.3	3.9	0.78	98	89.1339	65.2684
2015	7	23	6	53	24	0.3	3.9	0.82	96.5	89.1339	68.8944
2015	7	23	7	3	24	0.3	3.9	0.77	95.1	89.1339	65.2684
2015	7	23	7	13	24	0.3	3.9	0.83	95.5	89.0683	69.9564
2015	7	23	7	23	24	0.3	3.9	0.78	96.1	89.0683	65.497
2015	7	23	7	33	24	0.3	3.9	0.8	98.5	89.0683	66.8906
2015	7	23	7	43	24	0.3	3.9	0.81	97.2	89.0683	68.2841
2015	7	23	7	53	24	0.3	3.9	0.77	96.1	89.0683	65.2183
2015	7	23	8	3	24	0.3	3.9	0.81	96.5	89.0683	68.0054
2015	7	23	8	13	24	0.3	3.9	0.77	97.8	89.0683	64.9396
2015	7	23	8	23	24	0.3	3.9	0.74	98.4	89.0683	62.4312
2015	7	23	8	33	24	0.3	3.9	0.79	98.1	89.0026	66.5607
2015	7	23	8	43	24	0.3	3.9	0.77	97.1	89.0026	65.1682
2015	7	23	8	53	24	0.3	3.9	0.79	97.2	89.0026	66.5607
2015	7	23	9	3	24	0.3	3.9	0.76	99.4	89.0026	64.0542
2015	7	23	9	13	24	0.3	3.9	0.74	97.1	89.0026	62.3832
2015	7	23	9	23	24	0.3	3.9	0.73	96.7	89.0026	61.8262
2015	7	23	9	33	24	0.3	3.9	0.8	97.1	88.937	67.066
2015	7	23	9	43	24	0.3	3.9	0.76	98.4	88.937	64.0049
2015	7	23	9	53	24	0.3	3.9	0.75	98.5	88.937	63.17
2015	7	23	10	3	24	0.3	3.9	0.75	97.8	88.8714	63.1214
2015	7	23	10	13	24	0.3	3.9	0.76	95.7	88.8714	64.5117
2015	7	23	10	23	24	0.3	3.9	0.74	98.9	88.8058	62.2392
2015	7	23	10	33	24	0.3	3.9	0.77	97.9	88.7402	64.1346
2015	7	23	10	43	24	0.3	3.9	0.76	98	88.6745	63.2529
2015	7	23	10	53	24	0.3	3.9	0.77	97.3	88.6089	64.8673
2015	7	23	11	3	24	0.3	3.9	0.77	97.5	88.6089	64.8673
2015	7	23	11	13	24	0.3	3.9	0.75	97	88.6089	62.9268
2015	7	23	11	23	24	0.3	3.9	0.73	96.2	88.5433	60.9392
2015	7	23	11	33	24	0.3	3.9	0.75	96	88.5433	63.1551
2015	7	23	11	43	24	0.3	3.9	0.75	97	88.5433	62.8781
2015	7	23	11	53	24	0.3	3.9	0.76	98.7	88.5433	63.7091
2015	7	23	12	3	24	0.3	3.9	0.75	96.8	88.5433	63.155
2015	7	23	12	13	24	0.3	3.9	0.74	99.7	88.4777	61.4455
2015	7	23	12	23	24	0.3	3.9	0.77	98.3	88.4777	64.4901

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	23	12	33	24	0.3	3.9	0.75	97.8	88.4777	62.2758
2015	7	23	12	43	24	0.3	3.9	0.76	96.7	88.4777	63.9365
2015	7	23	12	53	24	0.3	3.9	0.75	96.3	88.4121	62.5041
2015	7	23	13	3	24	0.3	3.9	0.72	97.6	88.4121	60.2916
2015	7	23	13	13	24	0.3	3.9	0.76	95.2	88.4121	64.1635
2015	7	23	13	23	24	0.3	3.9	0.75	98.6	88.4121	62.504
2015	7	23	13	33	24	0.3	3.9	0.78	98	88.3465	65.2192
2015	7	23	13	43	24	0.3	3.9	0.75	96.3	88.3465	62.732
2015	7	23	13	53	24	0.3	3.9	0.73	96.5	88.3465	61.0738
2015	7	23	14	3	24	0.3	3.9	0.74	98.2	88.2808	61.5788
2015	7	23	14	13	24	0.3	3.9	0.74	97.1	88.2808	61.8549
2015	7	23	14	23	24	0.3	3.9	0.74	97.9	88.2808	61.8549
2015	7	23	14	33	24	0.3	3.9	0.73	97.4	88.1496	61.2075
2015	7	23	14	43	24	0.3	3.9	0.75	94.3	88.2152	62.6346
2015	7	23	14	53	24	0.3	3.9	0.73	94.9	88.1496	61.2075
2015	7	23	15	3	24	0.3	3.9	0.72	97.9	88.084	59.7825
2015	7	23	15	13	24	0.3	3.9	0.77	94.9	88.0184	64.1405
2015	7	23	15	23	24	0.3	3.9	0.76	96.9	87.9528	63.5405
2015	7	23	15	33	24	0.3	3.9	0.77	96.6	87.9528	64.0906
2015	7	23	15	43	24	0.3	3.9	0.71	96.9	87.9528	59.4144
2015	7	23	15	53	24	0.3	3.9	0.76	96.2	87.9528	63.5404
2015	7	23	16	3	24	0.3	3.9	0.74	94.1	87.8871	61.567
2015	7	23	16	13	24	0.3	3.9	0.73	96.2	87.8871	61.0173
2015	7	23	16	23	24	0.3	3.9	0.74	96.8	87.8215	61.7937
2015	7	23	16	33	24	0.3	3.9	0.74	97.9	87.8215	61.519
2015	7	23	16	43	24	0.3	3.9	0.73	98	87.8215	60.6951
2015	7	23	16	53	24	0.3	3.9	0.73	96.9	87.7559	60.9222
2015	7	23	17	3	24	0.3	3.9	0.8	96.4	87.7559	66.4107
2015	7	23	17	13	24	0.3	3.9	0.72	96.6	87.7559	59.5501
2015	7	23	17	23	24	0.3	3.9	0.73	97.4	87.7559	60.9222
2015	7	23	17	33	24	0.3	3.9	0.76	101	87.7559	62.2943
2015	7	23	17	43	24	0.3	3.9	0.76	96.2	87.6903	63.3426
2015	7	23	17	53	24	0.3	3.9	0.78	97.3	87.6903	64.4394
2015	7	23	18	3	24	0.3	3.9	0.72	96.5	87.6903	59.7779
2015	7	23	18	13	24	0.3	3.9	0.72	100.4	87.6903	59.5037
2015	7	23	18	23	24	0.3	3.9	0.71	99.5	87.6247	58.6352
2015	7	23	18	33	24	0.3	3.9	0.75	97.8	87.6903	61.9716
2015	7	23	18	43	24	0.3	3.9	0.73	96.7	87.6247	60.8272
2015	7	23	18	53	24	0.3	3.9	0.78	96.8	87.6247	64.6632
2015	7	23	19	3	24	0.3	3.9	0.78	98	87.6247	64.1152
2015	7	23	19	13	24	0.3	3.9	0.8	95.2	87.5591	66.2553
2015	7	23	19	23	24	0.3	3.9	0.75	98.8	87.5591	62.1486
2015	7	23	19	33	24	0.3	3.9	0.71	96.6	87.5591	59.137
2015	7	23	19	43	24	0.3	3.9	0.75	97.8	87.5591	61.8748
2015	7	23	19	53	24	0.3	3.9	0.77	97.3	87.5591	64.0651
2015	7	23	20	3	24	0.3	3.9	0.78	98.7	87.5591	64.0651
2015	7	23	20	13	24	0.3	3.9	0.73	96.5	87.5591	60.2321

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	23	20	23	24	0.3	3.9	0.77	97.1	87.4934	63.7414
2015	7	23	20	33	24	0.3	3.9	0.79	96.9	87.4934	65.6564
2015	7	23	20	43	24	0.3	3.9	0.72	96.1	87.4278	59.3179
2015	7	23	20	53	24	0.3	3.9	0.79	96	87.4278	65.0584
2015	7	23	21	3	24	0.3	3.9	0.76	99.5	87.3622	62.0029
2015	7	23	21	13	24	0.3	3.9	0.74	94.6	87.3622	61.7297
2015	7	23	21	23	24	0.3	3.9	0.72	94.5	87.3622	59.5446
2015	7	23	21	33	24	0.3	3.9	0.73	96.5	87.3622	60.364
2015	7	23	21	43	24	0.3	3.9	0.73	94.7	87.2966	60.3168
2015	7	23	21	53	24	0.3	3.9	0.77	98.4	87.2966	63.046
2015	7	23	22	3	24	0.3	3.9	0.77	98.1	87.2966	63.319
2015	7	23	22	13	24	0.3	3.9	0.78	97.5	87.2966	64.4107
2015	7	23	22	23	24	0.3	3.9	0.75	97.5	87.3622	62.2761
2015	7	23	22	33	24	0.3	3.9	0.78	96.7	87.2966	64.6836
2015	7	23	22	43	24	0.3	3.9	0.73	99	87.231	60.2695
2015	7	23	22	53	24	0.3	3.9	0.8	97.1	87.231	65.7238
2015	7	23	23	3	24	0.3	3.9	0.75	98.6	87.231	61.6331
2015	7	23	23	13	24	0.3	3.9	0.77	96.8	87.231	63.8148
2015	7	23	23	23	24	0.3	3.9	0.79	97.9	87.1654	65.1272
2015	7	23	23	33	24	0.3	3.9	0.81	99.3	87.1654	66.7622
2015	7	23	23	43	24	0.3	3.9	0.77	98.6	87.1654	62.9472
2015	7	23	23	53	24	0.3	3.9	0.82	95.7	87.1654	68.1247
2015	7	24	0	3	24	0.3	3.9	0.79	92.9	87.1654	65.3998
2015	7	24	0	13	24	0.3	3.9	0.72	99.4	87.0997	59.0859
2015	7	24	0	23	24	0.3	3.9	0.77	99	87.0997	63.4424
2015	7	24	0	33	24	0.3	3.9	0.76	99.2	87.0997	62.081
2015	7	24	0	43	24	0.3	3.9	0.78	95.5	87.0997	64.5316
2015	7	24	0	53	24	0.3	3.9	0.79	96.9	87.0997	64.8039
2015	7	24	1	3	24	0.3	3.9	0.81	96.8	87.0997	66.7099
2015	7	24	1	13	24	0.3	3.9	0.83	96.8	87.0997	68.3436
2015	7	24	1	23	24	0.3	3.9	0.76	96.9	87.0997	62.6256
2015	7	24	1	33	24	0.3	3.9	0.75	97.2	87.0997	62.0811
2015	7	24	1	43	24	0.3	3.9	0.79	97.2	87.0341	64.753
2015	7	24	1	53	24	0.3	3.9	0.75	97.5	87.0341	61.7603
2015	7	24	2	3	24	0.3	3.9	0.81	97.9	87.0341	66.9296
2015	7	24	2	13	24	0.3	3.9	0.78	93.6	87.0341	64.2089
2015	7	24	2	23	24	0.3	3.9	0.76	98.7	87.0341	62.3044
2015	7	24	2	33	24	0.3	3.9	0.75	97.5	87.0341	62.0324
2015	7	24	2	43	24	0.3	3.9	0.77	97.5	87.0341	63.6648
2015	7	24	2	53	24	0.3	3.9	0.78	97	87.0341	64.209
2015	7	24	3	3	24	0.3	3.9	0.77	97.3	87.0341	63.3928
2015	7	24	3	13	24	0.3	3.9	0.73	95.7	87.0341	60.1279
2015	7	24	3	23	24	0.3	3.9	0.79	94.8	87.0341	65.2973
2015	7	24	3	33	24	0.3	3.9	0.77	98.3	87.0341	63.1208
2015	7	24	3	43	24	0.3	3.9	0.81	97.2	87.0341	66.6577
2015	7	24	3	53	24	0.3	3.9	0.8	99.2	87.0341	65.5695
2015	7	24	4	3	24	0.3	3.9	0.78	96.5	87.0341	64.2091

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	24	4	13	24	0.3	3.9	0.76	98.4	86.9685	62.5275
2015	7	24	4	23	24	0.3	3.9	0.78	97.3	87.0341	63.9371
2015	7	24	4	33	24	0.3	3.9	0.76	97.2	86.9685	62.7994
2015	7	24	4	43	24	0.3	3.9	0.77	97.1	86.9685	63.615
2015	7	24	4	53	24	0.3	3.9	0.77	96.1	86.9685	63.615
2015	7	24	5	3	24	0.3	3.9	0.75	97	86.9685	61.712
2015	7	24	5	13	24	0.3	3.9	0.81	97	86.9685	66.3336
2015	7	24	5	23	24	0.3	3.9	0.78	96.5	86.9685	64.1588
2015	7	24	5	33	24	0.3	3.9	0.79	96.9	86.9685	64.9744
2015	7	24	5	43	24	0.3	3.9	0.75	97.5	86.9685	61.7121
2015	7	24	5	53	24	0.3	3.9	0.76	94.9	86.9685	63.0714
2015	7	24	6	3	24	0.3	3.9	0.77	94.6	86.9685	63.6151
2015	7	24	6	13	24	0.3	3.9	0.78	97.2	86.9685	64.1589
2015	7	24	6	23	24	0.3	3.9	0.75	96.8	86.9685	61.4403
2015	7	24	6	33	24	0.3	3.9	0.75	95	86.9685	62.2559
2015	7	24	6	43	24	0.3	3.9	0.74	98.2	86.9685	60.6248
2015	7	24	6	53	24	0.3	3.9	0.76	98.7	86.9685	61.9841
2015	7	24	7	3	24	0.3	3.9	0.79	96.2	86.9029	65.195
2015	7	24	7	13	24	0.3	3.9	0.79	98.6	86.9029	64.3801
2015	7	24	7	23	24	0.3	3.9	0.76	94.9	86.9029	62.7503
2015	7	24	7	33	24	0.3	3.9	0.77	97.3	86.9029	63.2935
2015	7	24	7	43	24	0.3	3.9	0.81	99.1	86.9029	66.01
2015	7	24	7	53	24	0.3	3.9	0.77	97.3	86.9029	63.2936
2015	7	24	8	3	24	0.3	3.9	0.79	95.9	86.9029	65.4667
2015	7	24	8	13	24	0.3	3.9	0.77	98.3	86.9029	63.2935
2015	7	24	8	23	24	0.3	3.9	0.77	100.6	86.9029	62.4786
2015	7	24	8	33	24	0.3	3.9	0.74	96.6	86.9029	60.8487
2015	7	24	8	43	24	0.3	3.9	0.79	97.2	86.9029	64.6518
2015	7	24	8	53	24	0.3	3.9	0.78	95.8	86.9029	64.1085
2015	7	24	9	3	24	0.3	3.9	0.77	94.9	86.9029	63.5652
2015	7	24	9	13	24	0.3	3.9	0.77	96.2	86.9029	63.0219
2015	7	24	9	23	24	0.3	3.9	0.78	96.3	86.9029	63.8368
2015	7	24	9	33	24	0.3	3.9	0.75	96.1	86.9029	61.392
2015	7	24	9	43	24	0.3	3.9	0.77	95.4	86.9029	63.5651
2015	7	24	9	53	24	0.3	3.9	0.76	98.7	86.9029	61.9352
2015	7	24	10	3	24	0.3	3.9	0.75	97.8	86.9029	61.6635
2015	7	24	10	13	24	0.3	3.9	0.78	97.2	86.9029	64.1083
2015	7	24	10	23	24	0.3	3.9	0.76	97	86.9029	62.2068
2015	7	24	10	33	24	0.3	3.9	0.78	98.4	86.8373	64.0578
2015	7	24	10	43	24	0.3	3.9	0.74	96.4	86.9029	60.5769
2015	7	24	10	53	24	0.3	3.9	0.75	98.5	86.8373	61.6149
2015	7	24	11	3	24	0.3	3.9	0.76	98	86.8373	61.8863
2015	7	24	11	13	24	0.3	3.9	0.76	99.7	86.8373	62.1577
2015	7	24	11	23	24	0.3	3.9	0.75	93.7	86.8373	62.1577
2015	7	24	11	33	24	0.3	3.9	0.79	98.1	86.8373	64.8719
2015	7	24	11	43	24	0.3	3.9	0.77	96.6	86.8373	63.2433
2015	7	24	11	53	24	0.3	3.9	0.75	98.6	86.8373	61.0719

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	24	12	3	24	0.3	3.9	0.74	97.9	86.8373	60.2576
2015	7	24	12	13	24	0.3	3.9	0.79	99.6	86.8373	64.329
2015	7	24	12	23	24	0.3	3.9	0.71	98.2	86.8373	58.3575
2015	7	24	12	33	24	0.3	3.9	0.75	96.3	86.8373	61.3432
2015	7	24	12	43	24	0.3	3.9	0.77	96.2	86.8373	62.9717
2015	7	24	12	53	24	0.3	3.9	0.7	99.4	86.8373	57.5431
2015	7	24	13	3	24	0.3	3.9	0.75	96.6	86.8373	61.3431
2015	7	24	13	13	24	0.3	3.9	0.75	96.3	86.8373	61.3431
2015	7	24	13	23	24	0.3	3.9	0.76	96.9	86.8373	62.4288
2015	7	24	13	33	24	0.3	3.9	0.72	100.5	86.8373	58.3573
2015	7	24	13	43	24	0.3	3.9	0.71	96.6	86.8373	58.3573
2015	7	24	13	53	24	0.3	3.9	0.74	99.5	86.8373	59.9859
2015	7	24	14	3	24	0.3	3.9	0.72	97.9	86.8373	58.9001
2015	7	24	14	13	24	0.3	3.9	0.71	100.2	86.8373	57.543
2015	7	24	14	23	24	0.3	3.9	0.71	99.6	86.8373	57.5429
2015	7	24	14	33	24	0.3	3.9	0.76	98.5	86.8373	61.8858
2015	7	24	14	43	24	0.3	3.9	0.76	96.2	86.8373	62.7001
2015	7	24	14	53	24	0.3	3.9	0.71	96.9	86.7717	58.0399
2015	7	24	15	3	24	0.3	3.9	0.76	97.2	86.7717	62.6506
2015	7	24	15	13	24	0.3	3.9	0.78	95.8	86.7717	64.2778
2015	7	24	15	23	24	0.3	3.9	0.76	96.2	86.8373	62.1572
2015	7	24	15	33	24	0.3	3.9	0.75	98.6	86.7717	61.2945
2015	7	24	15	43	24	0.3	3.9	0.72	97.1	86.8373	59.1714
2015	7	24	15	53	24	0.3	3.9	0.78	98.5	86.8373	63.5143
2015	7	24	16	3	24	0.3	3.9	0.76	96.2	86.8373	62.1571
2015	7	24	16	13	24	0.3	3.9	0.76	95.4	86.8373	62.9714
2015	7	24	16	23	24	0.3	3.9	0.78	97.2	86.8373	64.3285
2015	7	24	16	33	24	0.3	3.9	0.73	97	86.8373	59.7142
2015	7	24	16	43	24	0.3	3.9	0.77	96.9	86.8373	62.9714
2015	7	24	16	53	24	0.3	3.9	0.71	97.8	86.8373	57.8142
2015	7	24	17	3	24	0.3	3.9	0.74	98.4	86.8373	60.7999
2015	7	24	17	13	24	0.3	3.9	0.73	96.7	86.8373	60.2571
2015	7	24	17	23	24	0.3	3.9	0.74	96.1	86.8373	61.0714
2015	7	24	17	33	24	0.3	3.9	0.76	96.5	86.8373	62.1571
2015	7	24	17	43	24	0.3	3.9	0.8	97.3	86.8373	65.6857
2015	7	24	17	53	24	0.3	3.9	0.76	96.9	86.8373	62.7
2015	7	24	18	3	24	0.3	3.9	0.81	96.5	86.9029	66.824
2015	7	24	18	13	24	0.3	3.9	0.79	97.1	86.9029	65.1942
2015	7	24	18	23	24	0.3	3.9	0.77	98.9	86.9029	62.7494
2015	7	24	18	33	24	0.3	3.9	0.76	99.5	86.9029	61.6628
2015	7	24	18	43	24	0.3	3.9	0.73	98.2	86.9029	60.033
2015	7	24	18	53	24	0.3	3.9	0.75	97.6	86.9029	61.3912
2015	7	24	19	3	24	0.3	3.9	0.8	96.6	86.9029	65.7375
2015	7	24	19	13	24	0.3	3.9	0.78	96.6	86.9685	63.8863
2015	7	24	19	23	24	0.3	3.9	0.79	95.5	86.9685	64.9737
2015	7	24	19	33	24	0.3	3.9	0.79	94.8	86.9685	65.2456
2015	7	24	19	43	24	0.3	3.9	0.81	94.4	86.9685	66.8767

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	24	19	53	24	0.3	3.9	0.77	94.2	87.0341	63.3924
2015	7	24	20	3	24	0.3	3.9	0.77	98.9	87.0341	62.8483
2015	7	24	20	13	24	0.3	3.9	0.79	96.4	87.0341	65.297
2015	7	24	20	23	24	0.3	3.9	0.72	100	87.0341	58.7673
2015	7	24	20	33	24	0.3	3.9	0.78	96.3	87.0997	64.2592
2015	7	24	20	43	24	0.3	3.9	0.74	97.9	87.0997	60.4472
2015	7	24	20	53	24	0.3	3.9	0.84	96.8	87.1654	68.9422
2015	7	24	21	3	24	0.3	3.9	0.78	98.5	87.1654	63.7647
2015	7	24	21	13	24	0.3	3.9	0.75	95	87.231	61.9058
2015	7	24	21	23	24	0.3	3.9	0.82	93.9	87.3622	68.2853
2015	7	24	21	33	24	0.3	3.9	0.8	97	87.4278	66.4253
2015	7	24	21	43	24	0.3	3.9	0.76	94.9	87.4934	63.4681
2015	7	24	21	53	24	0.3	3.9	0.78	96.7	87.4934	64.836
2015	7	24	22	3	24	0.3	3.9	0.75	98.8	87.4934	61.8267
2015	7	24	22	13	24	0.3	3.9	0.8	99	87.5591	65.7081
2015	7	24	22	23	24	0.3	3.9	0.81	95.1	87.5591	67.3508
2015	7	24	22	33	24	0.3	3.9	0.78	95.3	87.5591	64.613
2015	7	24	22	43	24	0.3	3.9	0.77	98.1	87.6247	63.5675
2015	7	24	22	53	24	0.3	3.9	0.79	97.8	87.6247	65.7595
2015	7	24	23	3	24	0.3	3.9	0.77	97.8	87.6247	63.8416
2015	7	24	23	13	24	0.3	3.9	0.82	96.9	87.6247	67.9515
2015	7	24	23	23	24	0.3	3.9	0.78	98.2	87.6247	64.3896
2015	7	24	23	33	24	0.3	3.9	0.79	96.2	87.6903	65.5367
2015	7	24	23	43	24	0.3	3.9	0.78	98.7	87.6903	64.4399
2015	7	24	23	53	24	0.3	3.9	0.8	96.8	87.6903	66.6336
2015	7	25	0	3	24	0.3	3.9	0.79	98.6	87.7559	65.5879
2015	7	25	0	13	24	0.3	3.9	0.78	95.1	87.7559	64.7647
2015	7	25	0	23	24	0.3	3.9	0.77	98.6	87.7559	63.667
2015	7	25	0	33	24	0.3	3.9	0.81	96.3	87.8215	67.287
2015	7	25	0	43	24	0.3	3.9	0.84	97.6	87.8215	70.0334
2015	7	25	0	53	24	0.3	3.9	0.81	96.1	87.8215	67.287
2015	7	25	1	3	24	0.3	3.9	0.81	97.7	87.8215	67.0124
2015	7	25	1	13	24	0.3	3.9	0.82	97.2	87.9528	67.9421
2015	7	25	1	23	24	0.3	3.9	0.79	96.9	88.084	66.1194
2015	7	25	1	33	24	0.3	3.9	0.81	94.4	88.1496	67.5493
2015	7	25	1	43	24	0.3	3.9	0.8	97.6	88.1496	66.4465
2015	7	25	1	53	24	0.3	3.9	0.78	97	88.2152	64.8426
2015	7	25	2	3	24	0.3	3.9	0.78	96.3	88.2152	64.8426
2015	7	25	2	13	24	0.3	3.9	0.79	96.2	88.2152	66.2222
2015	7	25	2	23	24	0.3	3.9	0.77	97.8	88.2808	64.6168
2015	7	25	2	33	24	0.3	3.9	0.76	95.7	88.2808	63.5122
2015	7	25	2	43	24	0.3	3.9	0.81	96.7	88.3465	67.9832
2015	7	25	2	53	24	0.3	3.9	0.8	95.6	88.3465	67.1541
2015	7	25	3	3	24	0.3	3.9	0.8	95.9	88.3465	67.1541
2015	7	25	3	13	24	0.3	3.9	0.81	98.8	88.3465	67.7069
2015	7	25	3	23	24	0.3	3.9	0.82	98.5	88.3465	68.536
2015	7	25	3	33	24	0.3	3.9	0.78	96.5	88.3465	65.2197

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	25	3	43	24	0.3	3.9	0.81	97.7	88.3465	67.4306
2015	7	25	3	53	24	0.3	3.9	0.76	96.4	88.3465	63.5616
2015	7	25	4	3	24	0.3	3.9	0.76	97.4	88.4121	63.8875
2015	7	25	4	13	24	0.3	3.9	0.81	95.6	88.4121	67.7595
2015	7	25	4	23	24	0.3	3.9	0.82	97.8	88.4121	68.5892
2015	7	25	4	33	24	0.3	3.9	0.76	94.9	88.4121	63.8875
2015	7	25	4	43	24	0.3	3.9	0.79	95.5	88.4777	66.1513
2015	7	25	4	53	24	0.3	3.9	0.78	95.8	88.4777	65.5977
2015	7	25	5	3	24	0.3	3.9	0.81	96.8	88.4777	67.5352
2015	7	25	5	13	24	0.3	3.9	0.8	95.6	88.4777	67.2585
2015	7	25	5	23	24	0.3	3.9	0.8	95.7	88.4777	66.9817
2015	7	25	5	33	24	0.3	3.9	0.77	96.4	88.5433	64.5406
2015	7	25	5	43	24	0.3	3.9	0.81	95.4	88.6089	67.917
2015	7	25	5	53	24	0.3	3.9	0.79	97.2	88.6745	66.3049
2015	7	25	6	3	24	0.3	3.9	0.78	97.5	88.7402	65.8009
2015	7	25	6	13	24	0.3	3.9	0.81	96.3	88.8058	68.3524
2015	7	25	6	23	24	0.3	3.9	0.79	94.8	88.8058	66.4074
2015	7	25	6	33	24	0.3	3.9	0.78	99.5	88.8714	65.0682
2015	7	25	6	43	24	0.3	3.9	0.82	95.5	88.8714	68.9612
2015	7	25	6	53	24	0.3	3.9	0.79	96	88.8714	66.1806
2015	7	25	7	3	24	0.3	3.9	0.8	96.6	88.8714	67.5709
2015	7	25	7	13	24	0.3	3.9	0.79	94.8	88.937	66.5098
2015	7	25	7	23	24	0.3	3.9	0.8	95.9	88.937	67.623
2015	7	25	7	33	24	0.3	3.9	0.78	97	88.937	65.9533
2015	7	25	7	43	24	0.3	3.9	0.8	97.8	88.937	67.3447
2015	7	25	7	53	24	0.3	3.9	0.82	96.6	89.0026	69.346
2015	7	25	8	3	24	0.3	3.9	0.81	94.4	89.0026	68.789
2015	7	25	8	13	24	0.3	3.9	0.83	95.4	89.0026	70.1815
2015	7	25	8	23	24	0.3	3.9	0.84	97	89.0026	70.46
2015	7	25	8	33	24	0.3	3.9	0.77	96.9	89.0026	64.89
2015	7	25	8	43	24	0.3	3.9	0.82	96.7	89.0026	68.789
2015	7	25	8	53	24	0.3	3.9	0.8	95.6	89.0026	67.675
2015	7	25	9	3	24	0.3	3.9	0.8	95.2	89.0026	67.9535
2015	7	25	9	13	24	0.3	3.9	0.81	94.9	89.0683	68.8419
2015	7	25	9	23	24	0.3	3.9	0.81	97.5	89.0683	68.0057
2015	7	25	9	33	24	0.3	3.9	0.78	95	89.0683	66.3334
2015	7	25	9	43	24	0.3	3.9	0.79	98.4	89.0683	66.3334
2015	7	25	9	53	24	0.3	3.9	0.77	93.2	89.0683	65.4973
2015	7	25	10	3	24	0.3	3.9	0.76	98.4	89.0683	64.1037
2015	7	25	10	13	24	0.3	3.9	0.79	98.6	89.0683	66.0546
2015	7	25	10	23	24	0.3	3.9	0.78	96.5	89.0683	65.7759
2015	7	25	10	33	24	0.3	3.9	0.79	98.1	89.0683	66.612
2015	7	25	10	43	24	0.3	3.9	0.77	96.6	89.1339	64.9896
2015	7	25	10	53	24	0.3	3.9	0.8	96.1	89.1339	67.7789
2015	7	25	11	3	24	0.3	3.9	0.79	97.2	89.1339	66.3842
2015	7	25	11	13	24	0.3	3.9	0.79	95	89.1339	66.942
2015	7	25	11	23	24	0.3	3.9	0.78	98	89.1339	65.5473

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	25	11	33	24	0.3	3.9	0.76	98.5	89.1339	63.5949
2015	7	25	11	43	24	0.3	3.9	0.76	95.9	89.1339	64.4316
2015	7	25	11	53	24	0.3	3.9	0.78	99.7	89.1339	65.2683
2015	7	25	12	3	24	0.3	3.9	0.8	100.2	89.1339	66.9419
2015	7	25	12	13	24	0.3	3.9	0.76	97.4	89.1339	64.1526
2015	7	25	12	23	24	0.3	3.9	0.8	98	89.1339	67.2207
2015	7	25	12	33	24	0.3	3.9	0.75	95.5	89.1339	63.5947
2015	7	25	12	43	24	0.3	3.9	0.79	95	89.1339	66.6628
2015	7	25	12	53	24	0.3	3.9	0.74	95.1	89.1339	63.0368
2015	7	25	13	3	24	0.3	3.9	0.79	96.5	89.0026	66.2819
2015	7	25	13	13	24	0.3	3.9	0.77	95.6	89.1339	65.2681
2015	7	25	13	23	24	0.3	3.9	0.74	99	89.0683	61.8735
2015	7	25	13	33	24	0.3	3.9	0.76	97.2	89.0683	64.3818
2015	7	25	13	43	24	0.3	3.9	0.76	99.4	89.1339	63.8734
2015	7	25	13	53	24	0.3	3.9	0.81	96.8	89.1339	68.3362
2015	7	25	14	3	24	0.3	3.9	0.76	96.5	89.1339	63.8734
2015	7	25	14	13	24	0.3	3.9	0.75	95.8	89.0026	62.9398
2015	7	25	14	23	24	0.3	3.9	0.78	96.3	89.0683	65.4966
2015	7	25	14	33	24	0.3	3.9	0.76	97.2	89.1339	64.1523
2015	7	25	14	43	24	0.3	3.9	0.77	94.9	89.1339	64.989
2015	7	25	14	53	24	0.3	3.9	0.75	96.8	89.0683	62.9881
2015	7	25	15	3	24	0.3	3.9	0.76	96.2	89.0683	64.1029
2015	7	25	15	13	24	0.3	3.9	0.76	99.5	89.0683	63.2668
2015	7	25	15	23	24	0.3	3.9	0.72	96	89.0683	61.0371
2015	7	25	15	33	24	0.3	3.9	0.79	95	89.0683	66.6113
2015	7	25	15	43	24	0.3	3.9	0.76	97.2	89.0683	64.3816
2015	7	25	15	53	24	0.3	3.9	0.81	95.6	89.0683	68.5622
2015	7	25	16	3	24	0.3	3.9	0.79	96.7	89.0026	66.5601
2015	7	25	16	13	24	0.3	3.9	0.79	98.1	89.0026	66.2816
2015	7	25	16	23	24	0.3	3.9	0.77	95.4	89.0026	64.8891
2015	7	25	16	33	24	0.3	3.9	0.78	98.4	89.0026	65.7246
2015	7	25	16	43	24	0.3	3.9	0.8	99.7	89.0026	66.56
2015	7	25	16	53	24	0.3	3.9	0.73	97.5	88.937	61.4998
2015	7	25	17	3	24	0.3	3.9	0.76	97.2	88.937	64.2826
2015	7	25	17	13	24	0.3	3.9	0.79	96.4	89.0026	66.8385
2015	7	25	17	23	24	0.3	3.9	0.77	95.9	88.937	64.8392
2015	7	25	17	33	24	0.3	3.9	0.77	98.1	88.937	64.5609
2015	7	25	17	43	24	0.3	3.9	0.79	96.7	88.937	66.5089
2015	7	25	17	53	24	0.3	3.9	0.78	98.5	88.8714	65.0674
2015	7	25	18	3	24	0.3	3.9	0.78	98	88.937	65.1175
2015	7	25	18	13	24	0.3	3.9	0.77	96.8	88.937	65.1175
2015	7	25	18	23	24	0.3	3.9	0.78	97.2	88.937	65.674
2015	7	25	18	33	24	0.3	3.9	0.78	97.2	88.937	65.9523
2015	7	25	18	43	24	0.3	3.9	0.77	93.7	88.8714	65.3454
2015	7	25	18	53	24	0.3	3.9	0.8	97.8	88.937	67.3437
2015	7	25	19	3	24	0.3	3.9	0.83	95.9	88.937	70.1265
2015	7	25	19	13	24	0.3	3.9	0.75	98.8	88.937	62.6129

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	25	19	23	24	0.3	3.9	0.78	96.5	88.937	65.674
2015	7	25	19	33	24	0.3	3.9	0.79	96.4	88.937	66.7872
2015	7	25	19	43	24	0.3	3.9	0.78	97.2	89.0026	65.7246
2015	7	25	19	53	24	0.3	3.9	0.79	97.4	89.0026	66.5601
2015	7	25	20	3	24	0.3	3.9	0.81	97	88.937	68.1786
2015	7	25	20	13	24	0.3	3.9	0.77	95.6	89.0026	65.1676
2015	7	25	20	23	24	0.3	3.9	0.81	95.3	89.0026	68.5095
2015	7	25	20	33	24	0.3	3.9	0.8	94.5	89.0026	67.3956
2015	7	25	20	43	24	0.3	3.9	0.81	96.8	89.0026	68.2311
2015	7	25	20	53	24	0.3	3.9	0.82	95.5	89.0026	69.0666
2015	7	25	21	3	24	0.3	3.9	0.83	96.8	89.0026	69.902
2015	7	25	21	13	24	0.3	3.9	0.81	96.8	89.0026	68.2311
2015	7	25	21	23	24	0.3	3.9	0.81	95.6	89.0026	68.5096
2015	7	25	21	33	24	0.3	3.9	0.82	93.4	89.0026	69.9021
2015	7	25	21	43	24	0.3	3.9	0.74	96.4	89.0026	62.1042
2015	7	25	21	53	24	0.3	3.9	0.76	97.9	89.0026	64.0537
2015	7	25	22	3	24	0.3	3.9	0.79	97.9	89.0026	66.0032
2015	7	25	22	13	24	0.3	3.9	0.81	96.3	89.0026	68.5097
2015	7	25	22	23	24	0.3	3.9	0.77	97.1	89.0683	64.9391
2015	7	25	22	33	24	0.3	3.9	0.8	97.1	89.0683	67.1688
2015	7	25	22	43	24	0.3	3.9	0.81	97	89.0683	68.5624
2015	7	25	22	53	24	0.3	3.9	0.77	96.6	89.0683	64.9392
2015	7	25	23	3	24	0.3	3.9	0.81	96.7	89.0683	68.5624
2015	7	25	23	13	24	0.3	3.9	0.79	96.9	89.0683	66.3328
2015	7	25	23	23	24	0.3	3.9	0.81	95.8	89.0683	68.2837
2015	7	25	23	33	24	0.3	3.9	0.81	97.4	89.0683	68.5625
2015	7	25	23	43	24	0.3	3.9	0.79	97.2	89.0683	66.6115
2015	7	25	23	53	24	0.3	3.9	0.8	98.1	89.1339	66.9416
2015	7	26	0	3	24	0.3	3.9	0.8	96.6	89.1339	67.4995
2015	7	26	0	13	24	0.3	3.9	0.8	98.3	89.1339	66.9417
2015	7	26	0	23	24	0.3	3.9	0.75	95.8	89.1339	63.3157
2015	7	26	0	33	24	0.3	3.9	0.86	96.4	89.1339	72.5202
2015	7	26	0	43	24	0.3	3.9	0.77	95.6	89.1339	65.5471
2015	7	26	0	53	24	0.3	3.9	0.83	96.6	89.1339	69.731
2015	7	26	1	3	24	0.3	3.9	0.81	98.8	89.1339	68.3364
2015	7	26	1	13	24	0.3	3.9	0.76	95.4	89.1339	64.4315
2015	7	26	1	23	24	0.3	3.9	0.78	96.8	89.1339	65.5472
2015	7	26	1	33	24	0.3	3.9	0.79	94.5	89.1339	67.2207
2015	7	26	1	43	24	0.3	3.9	0.8	95.4	89.1339	68.0575
2015	7	26	1	53	24	0.3	3.9	0.79	95.9	89.1339	66.9418
2015	7	26	2	3	24	0.3	3.9	0.81	96.3	89.1339	68.0576
2015	7	26	2	13	24	0.3	3.9	0.82	96.5	89.1339	68.8944
2015	7	26	2	23	24	0.3	3.9	0.84	98.5	89.1339	70.8468
2015	7	26	2	33	24	0.3	3.9	0.78	99.2	89.1339	65.5473
2015	7	26	2	43	24	0.3	3.9	0.79	98.1	89.1995	66.7142
2015	7	26	2	53	24	0.3	3.9	0.81	96.3	89.1995	68.1099
2015	7	26	3	3	24	0.3	3.9	0.77	96.1	89.1995	65.3185

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	26	3	13	24	0.3	3.9	0.81	96.8	89.1995	68.3891
2015	7	26	3	23	24	0.3	3.9	0.79	96.7	89.1995	66.4351
2015	7	26	3	33	24	0.3	3.9	0.81	96	89.1995	68.9474
2015	7	26	3	43	24	0.3	3.9	0.79	96	89.1995	66.4352
2015	7	26	3	53	24	0.3	3.9	0.8	98.1	89.1995	66.9935
2015	7	26	4	3	24	0.3	3.9	0.81	96.3	89.1995	68.11
2015	7	26	4	13	24	0.3	3.9	0.79	95.7	89.1995	67.2726
2015	7	26	4	23	24	0.3	3.9	0.79	96.9	89.1995	66.7144
2015	7	26	4	33	24	0.3	3.9	0.84	96.5	89.1995	70.6224
2015	7	26	4	43	24	0.3	3.9	0.8	97.1	89.1995	67.2727
2015	7	26	4	53	24	0.3	3.9	0.8	97.5	89.1995	67.5519
2015	7	26	5	3	24	0.3	3.9	0.82	96	89.1995	69.2267
2015	7	26	5	13	24	0.3	3.9	0.81	96.5	89.2651	68.4418
2015	7	26	5	23	24	0.3	3.9	0.79	96.9	89.2651	67.0451
2015	7	26	5	33	24	0.3	3.9	0.78	95.3	89.2651	66.4864
2015	7	26	5	43	24	0.3	3.9	0.8	97.5	89.2651	67.6038
2015	7	26	5	53	24	0.3	3.9	0.8	95.9	89.2651	68.1626
2015	7	26	6	3	24	0.3	3.9	0.79	97.2	89.2651	66.7658
2015	7	26	6	13	24	0.3	3.9	0.77	97.6	89.2651	65.0897
2015	7	26	6	23	24	0.3	3.9	0.8	97.3	89.3307	67.9353
2015	7	26	6	33	24	0.3	3.9	0.78	96.3	89.3307	65.6988
2015	7	26	6	43	24	0.3	3.9	0.8	96.4	89.3963	67.4279
2015	7	26	6	53	24	0.3	3.9	0.79	96.4	89.462	66.9195
2015	7	26	7	3	24	0.3	3.9	0.8	95.9	89.5276	67.8114
2015	7	26	7	13	24	0.3	3.9	0.78	96.5	89.5276	66.4103
2015	7	26	7	23	24	0.3	3.9	0.84	97.4	89.5276	70.8937
2015	7	26	7	33	24	0.3	3.9	0.81	97.2	89.5276	68.6521
2015	7	26	7	43	24	0.3	3.9	0.78	97	89.5276	66.4104
2015	7	26	7	53	24	0.3	3.9	0.81	95.5	89.5276	69.2125
2015	7	26	8	3	24	0.3	3.9	0.81	95.6	89.5276	68.9323
2015	7	26	8	13	24	0.3	3.9	0.78	98.9	89.5276	66.1301
2015	7	26	8	23	24	0.3	3.9	0.82	97.6	89.5932	69.2654
2015	7	26	8	33	24	0.3	3.9	0.8	94.3	89.5932	67.8633
2015	7	26	8	43	24	0.3	3.9	0.78	97	89.5932	66.1807
2015	7	26	8	53	24	0.3	3.9	0.81	95.6	89.5932	68.7045
2015	7	26	9	3	24	0.3	3.9	0.79	96.9	89.5932	67.3024
2015	7	26	9	13	24	0.3	3.9	0.79	95.7	89.5932	67.3024
2015	7	26	9	23	24	0.3	3.9	0.83	97.5	89.5932	70.6675
2015	7	26	9	33	24	0.3	3.9	0.82	96.6	89.5932	69.8262
2015	7	26	9	43	24	0.3	3.9	0.79	96.9	89.5932	67.3023
2015	7	26	9	53	24	0.3	3.9	0.79	96.7	89.5932	66.7414
2015	7	26	10	3	24	0.3	3.9	0.78	99.5	89.5932	65.3393
2015	7	26	10	13	24	0.3	3.9	0.77	97.4	89.5932	65.0589
2015	7	26	10	23	24	0.3	3.9	0.76	95.7	89.5932	65.0588
2015	7	26	10	33	24	0.3	3.9	0.78	97	89.5932	65.9001
2015	7	26	10	43	24	0.3	3.9	0.79	95.9	89.5932	67.5826
2015	7	26	10	53	24	0.3	3.9	0.8	95.6	89.5932	68.1434

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	26	11	3	24	0.3	3.9	0.79	97.4	89.5932	67.3021
2015	7	26	11	13	24	0.3	3.9	0.78	97	89.5932	65.9
2015	7	26	11	23	24	0.3	3.9	0.77	95.9	89.5932	65.6195
2015	7	26	11	33	24	0.3	3.9	0.81	97.2	89.5932	68.7042
2015	7	26	11	43	24	0.3	3.9	0.79	97.1	89.5276	67.2506
2015	7	26	11	53	24	0.3	3.9	0.75	97.2	89.5276	63.8881
2015	7	26	12	3	24	0.3	3.9	0.73	98.2	89.5276	61.9266
2015	7	26	12	13	24	0.3	3.9	0.76	98.2	89.462	64.3992
2015	7	26	12	23	24	0.3	3.9	0.77	97.6	89.3963	65.1892
2015	7	26	12	33	24	0.3	3.9	0.76	98.5	89.3963	63.7903
2015	7	26	12	43	24	0.3	3.9	0.77	97.4	89.3307	64.8597
2015	7	26	12	53	24	0.3	3.9	0.75	99.8	89.3963	63.2307
2015	7	26	13	3	24	0.3	3.9	0.77	97.5	89.3307	65.4188
2015	7	26	13	13	24	0.3	3.9	0.77	100.9	89.3307	64.0209
2015	7	26	13	23	24	0.3	3.9	0.76	97.7	89.3307	64.0209
2015	7	26	13	33	24	0.3	3.9	0.76	96	89.3307	64.3004
2015	7	26	13	43	24	0.3	3.9	0.78	99.7	89.3307	65.4186
2015	7	26	13	53	24	0.3	3.9	0.77	97.1	89.2651	65.0892
2015	7	26	14	3	24	0.3	3.9	0.75	95	89.2651	63.9717
2015	7	26	14	13	24	0.3	3.9	0.75	98.1	89.2651	62.8543
2015	7	26	14	23	24	0.3	3.9	0.78	98.3	89.2651	65.3684
2015	7	26	14	33	24	0.3	3.9	0.73	99.3	89.2651	61.1781
2015	7	26	14	43	24	0.3	3.9	0.75	97	89.2651	63.4129
2015	7	26	14	53	24	0.3	3.9	0.74	99.2	89.1995	61.9686
2015	7	26	15	3	24	0.3	3.9	0.76	95.7	89.1995	64.76
2015	7	26	15	13	24	0.3	3.9	0.7	97.3	89.1339	58.8529
2015	7	26	15	23	24	0.3	3.9	0.83	97	89.1339	70.2887
2015	7	26	15	33	24	0.3	3.9	0.78	95.8	89.1995	66.1556
2015	7	26	15	43	24	0.3	3.9	0.75	95.3	89.1995	63.3642
2015	7	26	15	53	24	0.3	3.9	0.77	94.7	89.1339	64.9892
2015	7	26	16	3	24	0.3	3.9	0.76	97.7	89.1339	64.1524
2015	7	26	16	13	24	0.3	3.9	0.76	98.2	89.1339	64.1524
2015	7	26	16	23	24	0.3	3.9	0.74	97.3	89.1339	62.7577
2015	7	26	16	33	24	0.3	3.9	0.77	97.9	89.1339	64.4313
2015	7	26	16	43	24	0.3	3.9	0.8	98.3	89.1339	66.9416
2015	7	26	16	53	24	0.3	3.9	0.78	95.6	89.1339	65.8259
2015	7	26	17	3	24	0.3	3.9	0.77	96.2	89.1339	64.7102
2015	7	26	17	13	24	0.3	3.9	0.75	100.6	89.1339	62.7577
2015	7	26	17	23	24	0.3	3.9	0.78	96.3	89.0683	65.4966
2015	7	26	17	33	24	0.3	3.9	0.81	95.3	89.0683	68.8411
2015	7	26	17	43	24	0.3	3.9	0.82	94.8	88.937	69.2919
2015	7	26	17	53	24	0.3	3.9	0.88	93.2	88.937	74.5792
2015	7	26	18	3	24	0.3	3.9	0.76	97	88.937	63.7263
2015	7	26	18	13	24	0.3	3.9	0.8	96.8	88.8714	67.2921
2015	7	26	18	23	24	0.3	3.9	0.81	93.2	88.937	68.7353
2015	7	26	18	33	24	0.3	3.9	0.87	95.2	88.8714	73.6877
2015	7	26	18	43	24	0.3	3.9	0.83	97.9	88.937	69.8485

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	26	18	53	24	0.3	3.9	0.86	95.3	88.937	72.353
2015	7	26	19	3	24	0.3	3.9	0.81	96.5	88.8714	68.1263
2015	7	26	19	13	24	0.3	3.9	0.79	95.7	88.937	66.7874
2015	7	26	19	23	24	0.3	3.9	0.81	96.5	88.8714	67.8483
2015	7	26	19	33	24	0.3	3.9	0.79	95	88.8714	66.4579
2015	7	26	19	43	24	0.3	3.9	0.79	95.9	88.8714	67.0141
2015	7	26	19	53	24	0.3	3.9	0.86	94.8	88.8714	72.2973
2015	7	26	20	3	24	0.3	3.9	0.8	95.9	88.8714	67.5702
2015	7	26	20	13	24	0.3	3.9	0.85	94.2	88.8058	71.686
2015	7	26	20	23	24	0.3	3.9	0.84	95.6	88.7402	70.7978
2015	7	26	20	33	24	0.3	3.9	0.83	97	89.0026	70.1807
2015	7	26	20	43	24	0.3	3.9	0.81	96.8	89.0026	68.2313
2015	7	26	20	53	24	0.3	3.9	0.81	96.1	89.0026	68.2313
2015	7	26	21	3	24	0.3	3.9	0.79	98.1	89.0026	66.2818
2015	7	26	21	13	24	0.3	3.9	0.79	95	89.0026	66.5603
2015	7	26	21	23	24	0.3	3.9	0.78	95.1	89.0026	66.0034
2015	7	26	21	33	24	0.3	3.9	0.8	99.4	89.0026	67.1174
2015	7	26	21	43	24	0.3	3.9	0.81	97	88.937	68.4572
2015	7	26	21	53	24	0.3	3.9	0.78	96	88.937	65.6744
2015	7	26	22	3	24	0.3	3.9	0.8	96.3	88.937	67.6223
2015	7	26	22	13	24	0.3	3.9	0.76	97.2	88.937	63.7264
2015	7	26	22	23	24	0.3	3.9	0.78	96.7	88.8714	65.9019
2015	7	26	22	33	24	0.3	3.9	0.78	99.9	88.937	65.1179
2015	7	26	22	43	24	0.3	3.9	0.81	97.9	88.937	68.179
2015	7	26	22	53	24	0.3	3.9	0.83	96.8	88.937	69.5704
2015	7	26	23	3	24	0.3	3.9	0.8	96.4	88.937	67.0659
2015	7	26	23	13	24	0.3	3.9	0.79	96.4	88.937	66.7876
2015	7	26	23	23	24	0.3	3.9	0.79	95.7	88.937	66.7876
2015	7	26	23	33	24	0.3	3.9	0.75	96	88.937	63.4482
2015	7	26	23	43	24	0.3	3.9	0.82	94.6	88.937	69.0139
2015	7	26	23	53	24	0.3	3.9	0.81	97.9	88.937	67.9008
2015	7	27	0	3	24	0.3	3.9	0.77	97.3	88.937	65.118
2015	7	27	0	13	24	0.3	3.9	0.78	96.8	88.937	65.3963
2015	7	27	0	23	24	0.3	3.9	0.78	95.3	88.937	66.2311
2015	7	27	0	33	24	0.3	3.9	0.8	96.6	88.937	67.3443
2015	7	27	0	43	24	0.3	3.9	0.81	96.1	88.937	67.9009
2015	7	27	0	53	24	0.3	3.9	0.76	97.4	88.937	64.2832
2015	7	27	1	3	24	0.3	3.9	0.77	96.6	88.937	64.8398
2015	7	27	1	13	24	0.3	3.9	0.79	95	88.937	66.7878
2015	7	27	1	23	24	0.3	3.9	0.78	96.7	88.937	65.9529
2015	7	27	1	33	24	0.3	3.9	0.78	95.8	88.937	65.953
2015	7	27	1	43	24	0.3	3.9	0.78	96.1	88.937	65.3964
2015	7	27	1	53	24	0.3	3.9	0.81	96.8	88.937	68.1793
2015	7	27	2	3	24	0.3	3.9	0.81	94.9	88.937	68.7359
2015	7	27	2	13	24	0.3	3.9	0.79	95.7	88.937	66.7879
2015	7	27	2	23	24	0.3	3.9	0.81	95.3	88.937	68.7359
2015	7	27	2	33	24	0.3	3.9	0.8	96.1	88.937	67.3445

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	27	2	43	24	0.3	3.9	0.82	96.7	88.937	69.0142
2015	7	27	2	53	24	0.3	3.9	0.78	97.2	88.937	65.6749
2015	7	27	3	3	24	0.3	3.9	0.79	97.2	88.937	66.2315
2015	7	27	3	13	24	0.3	3.9	0.8	97.3	88.937	67.6229
2015	7	27	3	23	24	0.3	3.9	0.76	95.9	88.937	64.2835
2015	7	27	3	33	24	0.3	3.9	0.79	96.9	88.937	66.7881
2015	7	27	3	43	24	0.3	3.9	0.79	98.1	88.937	66.5098
2015	7	27	3	53	24	0.3	3.9	0.81	96	88.8714	68.6832
2015	7	27	4	3	24	0.3	3.9	0.8	95.7	88.8714	67.2929
2015	7	27	4	13	24	0.3	3.9	0.79	97.4	88.8714	66.7368
2015	7	27	4	23	24	0.3	3.9	0.8	94.5	88.8714	67.8491
2015	7	27	4	33	24	0.3	3.9	0.8	95.7	88.8714	67.293
2015	7	27	4	43	24	0.3	3.9	0.77	93.4	88.8714	65.0684
2015	7	27	4	53	24	0.3	3.9	0.77	97.4	88.937	64.562
2015	7	27	5	3	24	0.3	3.9	0.8	96.9	88.8714	67.015
2015	7	27	5	13	24	0.3	3.9	0.79	96.2	88.8714	66.7369
2015	7	27	5	23	24	0.3	3.9	0.77	97.9	88.8714	64.5124
2015	7	27	5	33	24	0.3	3.9	0.83	96.6	88.8714	69.7957
2015	7	27	5	43	24	0.3	3.9	0.84	94.5	88.8714	70.6299
2015	7	27	5	53	24	0.3	3.9	0.8	97.7	88.8714	67.5712
2015	7	27	6	3	24	0.3	3.9	0.8	95.6	88.8714	67.8493
2015	7	27	6	13	24	0.3	3.9	0.8	98.3	88.8714	67.0151
2015	7	27	6	23	24	0.3	3.9	0.76	93.2	88.8714	64.5125
2015	7	27	6	33	24	0.3	3.9	0.78	95.8	88.8714	65.9028
2015	7	27	6	43	24	0.3	3.9	0.8	98	88.8714	67.0151
2015	7	27	6	53	24	0.3	3.9	0.8	98.2	88.8714	67.2932
2015	7	27	7	3	24	0.3	3.9	0.77	98.9	88.8714	64.2345
2015	7	27	7	13	24	0.3	3.9	0.81	95.8	88.8714	68.4056
2015	7	27	7	23	24	0.3	3.9	0.82	97.3	88.8714	69.2398
2015	7	27	7	33	24	0.3	3.9	0.79	96	88.8714	66.4591
2015	7	27	7	43	24	0.3	3.9	0.8	96.2	88.8714	67.0152
2015	7	27	7	53	24	0.3	3.9	0.84	96.5	88.8714	70.6301
2015	7	27	8	3	24	0.3	3.9	0.79	95.7	88.8714	66.7371
2015	7	27	8	13	24	0.3	3.9	0.8	95.7	88.8714	67.2933
2015	7	27	8	23	24	0.3	3.9	0.79	96.9	88.8714	66.181
2015	7	27	8	33	24	0.3	3.9	0.77	97.4	88.8058	64.4629
2015	7	27	8	43	24	0.3	3.9	0.78	97	88.8058	65.5743
2015	7	27	8	53	24	0.3	3.9	0.79	96.7	88.8058	66.6858
2015	7	27	9	3	24	0.3	3.9	0.74	96.6	88.8058	62.5179
2015	7	27	9	13	24	0.3	3.9	0.76	95.7	88.8058	64.185
2015	7	27	9	23	24	0.3	3.9	0.73	96.5	88.8058	61.4064
2015	7	27	9	33	24	0.3	3.9	0.8	95.7	88.8058	67.2414
2015	7	27	9	43	24	0.3	3.9	0.78	95.8	88.8058	66.13
2015	7	27	9	53	24	0.3	3.9	0.78	95.8	88.8058	65.8521
2015	7	27	10	3	24	0.3	3.9	0.78	97	88.8058	65.2964
2015	7	27	10	13	24	0.3	3.9	0.78	97.7	88.8058	65.8521
2015	7	27	10	23	24	0.3	3.9	0.79	96.9	88.8058	66.6856

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	27	10	33	24	0.3	3.9	0.78	96.3	88.8058	65.2963
2015	7	27	10	43	24	0.3	3.9	0.77	95.4	88.7402	64.9683
2015	7	27	10	53	24	0.3	3.9	0.78	97.5	88.7402	65.246
2015	7	27	11	3	24	0.3	3.9	0.76	96.2	88.7402	63.5801
2015	7	27	11	13	24	0.3	3.9	0.76	95.2	88.7402	63.8577
2015	7	27	11	23	24	0.3	3.9	0.81	95.6	88.6745	67.9698
2015	7	27	11	33	24	0.3	3.9	0.8	97.5	88.6745	67.1375
2015	7	27	11	43	24	0.3	3.9	0.78	97.5	88.6089	65.1452
2015	7	27	11	53	24	0.3	3.9	0.76	93.7	88.5433	63.7098
2015	7	27	12	3	24	0.3	3.9	0.77	96.6	88.4777	64.2141
2015	7	27	12	13	24	0.3	3.9	0.81	95.3	88.4777	68.3659
2015	7	27	12	23	24	0.3	3.9	0.79	97.4	88.4777	65.8748
2015	7	27	12	33	24	0.3	3.9	0.76	94.4	88.4777	64.214
2015	7	27	12	43	24	0.3	3.9	0.79	94.5	88.4777	66.4283
2015	7	27	12	53	24	0.3	3.9	0.79	95.9	88.4777	66.705
2015	7	27	13	3	24	0.3	3.9	0.77	97.3	88.4777	64.4907
2015	7	27	13	13	24	0.3	3.9	0.77	97.9	88.4777	63.9371
2015	7	27	13	23	24	0.3	3.9	0.79	95.2	88.4121	66.6534
2015	7	27	13	33	24	0.3	3.9	0.79	93.3	88.4121	66.6533
2015	7	27	13	43	24	0.3	3.9	0.81	95.8	88.4121	68.0361
2015	7	27	13	53	24	0.3	3.9	0.77	95.9	88.4121	64.4407
2015	7	27	14	3	24	0.3	3.9	0.78	95.8	88.4121	65.547
2015	7	27	14	13	24	0.3	3.9	0.77	96.1	88.4121	64.7172
2015	7	27	14	23	24	0.3	3.9	0.75	97.2	88.4121	63.0578
2015	7	27	14	33	24	0.3	3.9	0.82	95.8	88.4121	68.5891
2015	7	27	14	43	24	0.3	3.9	0.77	95.1	88.4121	64.7172
2015	7	27	14	53	24	0.3	3.9	0.78	98	88.3465	64.9434
2015	7	27	15	3	24	0.3	3.9	0.77	96.1	88.3465	64.667
2015	7	27	15	13	24	0.3	3.9	0.76	97.7	88.3465	63.5616
2015	7	27	15	23	24	0.3	3.9	0.82	96.4	88.3465	68.8123
2015	7	27	15	33	24	0.3	3.9	0.82	96.7	88.3465	68.5359
2015	7	27	15	43	24	0.3	3.9	0.78	98.9	88.3465	65.2197
2015	7	27	15	53	24	0.3	3.9	0.76	95.5	88.3465	63.5615
2015	7	27	16	3	24	0.3	3.9	0.79	95.7	88.2808	65.9975
2015	7	27	16	13	24	0.3	3.9	0.81	98.4	88.3465	67.4305
2015	7	27	16	23	24	0.3	3.9	0.79	96.9	88.3465	65.7723
2015	7	27	16	33	24	0.3	3.9	0.8	98.1	88.3465	66.325
2015	7	27	16	43	24	0.3	3.9	0.78	94.8	88.3465	65.496
2015	7	27	16	53	24	0.3	3.9	0.77	97.8	88.3465	64.6669
2015	7	27	17	3	24	0.3	3.9	0.78	96.3	88.3465	65.496
2015	7	27	17	13	24	0.3	3.9	0.81	97.7	88.3465	67.7068
2015	7	27	17	23	24	0.3	3.9	0.81	96.5	88.3465	67.4304
2015	7	27	17	33	24	0.3	3.9	0.78	96.3	88.2808	65.4452
2015	7	27	17	43	24	0.3	3.9	0.74	96.4	88.2808	61.5793
2015	7	27	17	53	24	0.3	3.9	0.81	97.9	88.2808	67.9305
2015	7	27	18	3	24	0.3	3.9	0.78	94.6	88.2808	65.7214
2015	7	27	18	13	24	0.3	3.9	0.81	97.2	88.2808	67.6543

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	27	18	23	24	0.3	3.9	0.78	98.2	88.2808	65.1691
2015	7	27	18	33	24	0.3	3.9	0.77	97.1	88.2808	64.3407
2015	7	27	18	43	24	0.3	3.9	0.81	97.7	88.2808	67.3782
2015	7	27	18	53	24	0.3	3.9	0.83	96.6	88.2808	69.5873
2015	7	27	19	3	24	0.3	3.9	0.78	96.3	88.2808	65.4452
2015	7	27	19	13	24	0.3	3.9	0.8	96.1	88.2808	66.8259
2015	7	27	19	23	24	0.3	3.9	0.82	95.5	88.2808	69.035
2015	7	27	19	33	24	0.3	3.9	0.8	95.7	88.2808	66.8259
2015	7	27	19	43	24	0.3	3.9	0.81	96.1	88.2808	67.3782
2015	7	27	19	53	24	0.3	3.9	0.79	96.9	88.3465	66.0487
2015	7	27	20	3	24	0.3	3.9	0.81	96.3	88.2808	67.3782
2015	7	27	20	13	24	0.3	3.9	0.8	96.4	88.3465	66.6014
2015	7	27	20	23	24	0.3	3.9	0.81	97	88.3465	67.4305
2015	7	27	20	33	24	0.3	3.9	0.77	95.3	88.3465	64.9433
2015	7	27	20	43	24	0.3	3.9	0.79	98.1	88.3465	66.0487
2015	7	27	20	53	24	0.3	3.9	0.76	94.9	88.3465	64.1143
2015	7	27	21	3	24	0.3	3.9	0.77	96.6	88.3465	64.3906
2015	7	27	21	13	24	0.3	3.9	0.79	95.9	88.3465	66.6015
2015	7	27	21	23	24	0.3	3.9	0.77	98.3	88.3465	64.3907
2015	7	27	21	33	24	0.3	3.9	0.83	98.2	88.3465	68.8123
2015	7	27	21	43	24	0.3	3.9	0.78	99.5	88.3465	64.3907
2015	7	27	21	53	24	0.3	3.9	0.79	96.7	88.3465	66.0488
2015	7	27	22	3	24	0.3	3.9	0.8	96.3	88.3465	67.1543
2015	7	27	22	13	24	0.3	3.9	0.75	97.5	88.3465	62.7326
2015	7	27	22	23	24	0.3	3.9	0.82	93.2	88.3465	68.8124
2015	7	27	22	33	24	0.3	3.9	0.8	94.2	88.3465	67.4307
2015	7	27	22	43	24	0.3	3.9	0.81	97.2	88.3465	67.707
2015	7	27	22	53	24	0.3	3.9	0.79	97.2	88.3465	66.0489
2015	7	27	23	3	24	0.3	3.9	0.79	97.1	88.4121	66.3767
2015	7	27	23	13	24	0.3	3.9	0.78	96.8	88.4121	64.9939
2015	7	27	23	23	24	0.3	3.9	0.76	97.5	88.4121	63.3345
2015	7	27	23	33	24	0.3	3.9	0.79	97.7	88.4121	65.8236
2015	7	27	23	43	24	0.3	3.9	0.8	94.9	88.4121	67.2065
2015	7	27	23	53	24	0.3	3.9	0.79	96.4	88.4121	66.1002
2015	7	28	0	3	24	0.3	3.9	0.77	98.4	88.4121	63.8877
2015	7	28	0	13	24	0.3	3.9	0.81	96.7	88.4777	68.0889
2015	7	28	0	23	24	0.3	3.9	0.8	95	88.4777	66.9818
2015	7	28	0	33	24	0.3	3.9	0.82	96.4	88.4777	68.6425
2015	7	28	0	43	24	0.3	3.9	0.8	99.2	88.4777	66.9818
2015	7	28	0	53	24	0.3	3.9	0.81	95.5	88.4777	68.3658
2015	7	28	1	3	24	0.3	3.9	0.83	96.6	88.4777	69.1962
2015	7	28	1	13	24	0.3	3.9	0.81	94.4	88.4777	68.089
2015	7	28	1	23	24	0.3	3.9	0.82	98.3	88.5433	68.4187
2015	7	28	1	33	24	0.3	3.9	0.78	95.5	88.6089	65.9767
2015	7	28	1	43	24	0.3	3.9	0.77	96.2	88.6745	64.3631
2015	7	28	1	53	24	0.3	3.9	0.8	95.9	88.7402	67.4669
2015	7	28	2	3	24	0.3	3.9	0.79	99.3	88.7402	66.0787

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	28	2	13	24	0.3	3.9	0.79	95.3	88.8058	66.4075
2015	7	28	2	23	24	0.3	3.9	0.81	97.4	88.8058	68.3526
2015	7	28	2	33	24	0.3	3.9	0.82	96.5	88.8058	68.6304
2015	7	28	2	43	24	0.3	3.9	0.78	97.7	88.8058	65.574
2015	7	28	2	53	24	0.3	3.9	0.78	96	88.8714	65.6246
2015	7	28	3	3	24	0.3	3.9	0.78	96.7	88.8714	65.9027
2015	7	28	3	13	24	0.3	3.9	0.79	98.1	88.8714	66.4588
2015	7	28	3	23	24	0.3	3.9	0.77	97.1	88.8714	65.0685
2015	7	28	3	33	24	0.3	3.9	0.77	96.4	88.8714	64.5124
2015	7	28	3	43	24	0.3	3.9	0.81	96.7	88.937	68.4581
2015	7	28	3	53	24	0.3	3.9	0.8	97.3	88.937	67.6232
2015	7	28	4	3	24	0.3	3.9	0.81	96.3	88.937	67.9015
2015	7	28	4	13	24	0.3	3.9	0.8	95.9	88.937	67.9016
2015	7	28	4	23	24	0.3	3.9	0.8	95.9	88.937	67.9016
2015	7	28	4	33	24	0.3	3.9	0.81	95.4	88.937	68.1799
2015	7	28	4	43	24	0.3	3.9	0.82	97.6	88.937	69.0148
2015	7	28	4	53	24	0.3	3.9	0.79	95.7	88.937	66.7885
2015	7	28	5	3	24	0.3	3.9	0.8	95.7	88.937	67.3451
2015	7	28	5	13	24	0.3	3.9	0.81	96.3	88.937	68.4582
2015	7	28	5	23	24	0.3	3.9	0.77	96.1	88.937	65.1188
2015	7	28	5	33	24	0.3	3.9	0.76	95.2	88.937	64.0057
2015	7	28	5	43	24	0.3	3.9	0.78	97	88.937	65.6755
2015	7	28	5	53	24	0.3	3.9	0.79	96.2	89.0026	66.84
2015	7	28	6	3	24	0.3	3.9	0.8	95.2	88.937	67.3452
2015	7	28	6	13	24	0.3	3.9	0.81	96.7	89.0026	68.5111
2015	7	28	6	23	24	0.3	3.9	0.79	96.9	89.0026	66.5616
2015	7	28	6	33	24	0.3	3.9	0.83	94.7	89.0026	70.4606
2015	7	28	6	43	24	0.3	3.9	0.81	96.3	89.0026	68.2326
2015	7	28	6	53	24	0.3	3.9	0.79	95.7	89.0026	67.1186
2015	7	28	7	3	24	0.3	3.9	0.78	97.2	89.0026	66.0046
2015	7	28	7	13	24	0.3	3.9	0.81	97	89.0026	67.9542
2015	7	28	7	23	24	0.3	3.9	0.81	97	89.0026	68.2327
2015	7	28	7	33	24	0.3	3.9	0.83	98.2	89.0683	69.6787
2015	7	28	7	43	24	0.3	3.9	0.8	96.8	89.0683	67.449
2015	7	28	7	53	24	0.3	3.9	0.81	97.2	89.0026	68.5112
2015	7	28	8	3	24	0.3	3.9	0.83	98	89.0683	69.6787
2015	7	28	8	13	24	0.3	3.9	0.79	96.2	89.0683	66.8916
2015	7	28	8	23	24	0.3	3.9	0.78	95.8	89.0683	66.3341
2015	7	28	8	33	24	0.3	3.9	0.82	96.7	89.0683	69.1213
2015	7	28	8	43	24	0.3	3.9	0.79	96.4	89.0683	66.6128
2015	7	28	8	53	24	0.3	3.9	0.76	97.2	89.0683	64.1044
2015	7	28	9	3	24	0.3	3.9	0.78	97	89.0683	65.498
2015	7	28	9	13	24	0.3	3.9	0.79	95.7	89.0683	67.1702
2015	7	28	9	23	24	0.3	3.9	0.82	94.8	89.0683	69.1212
2015	7	28	9	33	24	0.3	3.9	0.78	96	89.0683	66.0554
2015	7	28	9	43	24	0.3	3.9	0.81	98.8	89.0683	68.285
2015	7	28	9	53	24	0.3	3.9	0.8	96.2	89.0683	67.1702

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	28	10	3	24	0.3	3.9	0.74	94.3	89.0683	62.432
2015	7	28	10	13	24	0.3	3.9	0.76	97.2	89.0683	64.1043
2015	7	28	10	23	24	0.3	3.9	0.8	94.5	89.0683	68.0063
2015	7	28	10	33	24	0.3	3.9	0.75	96.3	89.0683	62.9894
2015	7	28	10	43	24	0.3	3.9	0.76	97.6	89.0683	64.3829
2015	7	28	10	53	24	0.3	3.9	0.76	95.4	89.0683	64.6616
2015	7	28	11	3	24	0.3	3.9	0.83	97	89.0683	69.9571
2015	7	28	11	13	24	0.3	3.9	0.8	96.4	89.0683	67.4487
2015	7	28	11	23	24	0.3	3.9	0.81	95.5	89.0683	68.8422
2015	7	28	11	33	24	0.3	3.9	0.78	95	89.0683	66.3338
2015	7	28	11	43	24	0.3	3.9	0.77	99.5	89.0683	64.6615
2015	7	28	11	53	24	0.3	3.9	0.79	95	89.0683	66.8911
2015	7	28	12	3	24	0.3	3.9	0.81	94.2	89.0683	68.2847
2015	7	28	12	13	24	0.3	3.9	0.78	96.8	89.0683	65.4975
2015	7	28	12	23	24	0.3	3.9	0.81	95.8	89.0683	68.5633
2015	7	28	12	33	24	0.3	3.9	0.79	97.9	89.0683	66.0549
2015	7	28	12	43	24	0.3	3.9	0.79	96.9	89.0683	66.6123
2015	7	28	12	53	24	0.3	3.9	0.82	95.3	89.0683	69.6781
2015	7	28	13	3	24	0.3	3.9	0.77	96.4	89.0683	64.6612
2015	7	28	13	13	24	0.3	3.9	0.78	99.2	89.0683	65.4973
2015	7	28	13	23	24	0.3	3.9	0.77	96.4	89.0683	64.6611
2015	7	28	13	33	24	0.3	3.9	0.77	98.1	89.0026	64.8899
2015	7	28	13	43	24	0.3	3.9	0.8	96.8	89.0026	67.3964
2015	7	28	13	53	24	0.3	3.9	0.77	94.9	89.0026	65.1684
2015	7	28	14	3	24	0.3	3.9	0.84	96.5	89.0026	70.7383
2015	7	28	14	13	24	0.3	3.9	0.81	96.7	89.0026	68.5103
2015	7	28	14	23	24	0.3	3.9	0.8	96.6	89.0026	67.3963
2015	7	28	14	33	24	0.3	3.9	0.75	96.8	89.0026	63.4973
2015	7	28	14	43	24	0.3	3.9	0.79	97.1	88.937	66.7878
2015	7	28	14	53	24	0.3	3.9	0.78	96.7	88.937	65.953
2015	7	28	15	3	24	0.3	3.9	0.78	98.3	88.937	65.1181
2015	7	28	15	13	24	0.3	3.9	0.77	94.7	88.937	64.8398
2015	7	28	15	23	24	0.3	3.9	0.74	97.6	88.937	62.6135
2015	7	28	15	33	24	0.3	3.9	0.76	98.4	88.8714	63.6776
2015	7	28	15	43	24	0.3	3.9	0.78	98	88.8714	65.346
2015	7	28	15	53	24	0.3	3.9	0.8	97.5	88.8714	67.5705
2015	7	28	16	3	24	0.3	3.9	0.75	98.5	88.8714	63.1214
2015	7	28	16	13	24	0.3	3.9	0.79	95.9	88.8058	66.6849
2015	7	28	16	23	24	0.3	3.9	0.78	96	88.8058	65.5735
2015	7	28	16	33	24	0.3	3.9	0.81	96.5	88.7402	67.7441
2015	7	28	16	43	24	0.3	3.9	0.77	96.8	88.6745	64.9175
2015	7	28	16	53	24	0.3	3.9	0.79	94.5	88.6745	66.5821
2015	7	28	17	3	24	0.3	3.9	0.79	96.9	88.6089	65.9763
2015	7	28	17	13	24	0.3	3.9	0.8	97.3	88.5433	67.0333
2015	7	28	17	23	24	0.3	3.9	0.78	95.1	88.5433	65.6483
2015	7	28	17	33	24	0.3	3.9	0.82	97.2	88.6089	68.4712
2015	7	28	17	43	24	0.3	3.9	0.79	94.3	88.5433	66.4793

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	28	17	53	24	0.3	3.9	0.79	95.9	88.6089	66.8079
2015	7	28	18	3	24	0.3	3.9	0.8	95.2	88.5433	67.3103
2015	7	28	18	13	24	0.3	3.9	0.81	98	88.4777	67.2583
2015	7	28	18	23	24	0.3	3.9	0.83	96.1	88.4777	70.0261
2015	7	28	18	33	24	0.3	3.9	0.8	99.2	88.4777	66.7047
2015	7	28	18	43	24	0.3	3.9	0.81	95.5	88.4777	68.3654
2015	7	28	18	53	24	0.3	3.9	0.83	93.4	88.4121	69.9719
2015	7	28	19	3	24	0.3	3.9	0.82	94.4	88.4121	68.5891
2015	7	28	19	13	24	0.3	3.9	0.87	95.6	88.4121	73.0142
2015	7	28	19	23	24	0.3	3.9	0.86	93.5	88.4121	72.461
2015	7	28	19	33	24	0.3	3.9	0.86	94.2	88.4777	72.2403
2015	7	28	19	43	24	0.3	3.9	0.79	94.8	88.4777	66.4279
2015	7	28	19	53	24	0.3	3.9	0.83	95.4	88.4777	70.0261
2015	7	28	20	3	24	0.3	3.9	0.88	94.7	88.4121	73.5673
2015	7	28	20	13	24	0.3	3.9	0.83	94.1	88.3465	69.6414
2015	7	28	20	23	24	0.3	3.9	0.81	93.7	88.3465	68.2596
2015	7	28	20	33	24	0.3	3.9	0.8	95.4	88.4121	66.9297
2015	7	28	20	43	24	0.3	3.9	0.79	97.7	88.4121	65.8234
2015	7	28	20	53	24	0.3	3.9	0.85	95.3	88.4121	71.0783
2015	7	28	21	3	24	0.3	3.9	0.81	96.3	88.4121	68.036
2015	7	28	21	13	24	0.3	3.9	0.81	96.8	88.4121	67.4829
2015	7	28	21	23	24	0.3	3.9	0.78	94.3	88.4121	65.5469
2015	7	28	21	33	24	0.3	3.9	0.76	94.9	88.3465	63.838
2015	7	28	21	43	24	0.3	3.9	0.79	97.2	88.3465	66.0489
2015	7	28	21	53	24	0.3	3.9	0.78	97.5	88.3465	65.4962
2015	7	28	22	3	24	0.3	3.9	0.79	97.2	88.3465	66.0489
2015	7	28	22	13	24	0.3	3.9	0.8	95.9	88.3465	67.4307
2015	7	28	22	23	24	0.3	3.9	0.82	96.2	88.3465	68.5361
2015	7	28	22	33	24	0.3	3.9	0.77	97.3	88.3465	64.6672
2015	7	28	22	43	24	0.3	3.9	0.8	97	88.3465	67.1544
2015	7	28	22	53	24	0.3	3.9	0.81	98.4	88.3465	67.7071
2015	7	28	23	3	24	0.3	3.9	0.77	98.8	88.3465	64.3909
2015	7	28	23	13	24	0.3	3.9	0.78	95.1	88.3465	65.4963
2015	7	28	23	23	24	0.3	3.9	0.78	97.2	88.2808	65.1695
2015	7	28	23	33	24	0.3	3.9	0.79	95.7	88.3465	66.3254
2015	7	28	23	43	24	0.3	3.9	0.78	95.3	88.3465	65.22
2015	7	28	23	53	24	0.3	3.9	0.8	99.2	88.2808	66.8264
2015	7	29	0	3	24	0.3	3.9	0.81	94.9	88.2808	67.6548
2015	7	29	0	13	24	0.3	3.9	0.77	96.6	88.2808	64.6173
2015	7	29	0	23	24	0.3	3.9	0.83	96.6	88.2808	69.5879
2015	7	29	0	33	24	0.3	3.9	0.82	97.8	88.2808	68.4833
2015	7	29	0	43	24	0.3	3.9	0.82	96	88.2808	68.4833
2015	7	29	0	53	24	0.3	3.9	0.77	94.9	88.2808	64.6174
2015	7	29	1	3	24	0.3	3.9	0.76	95.2	88.2808	63.5128
2015	7	29	1	13	24	0.3	3.9	0.77	96.1	88.2808	64.6174
2015	7	29	1	23	24	0.3	3.9	0.8	96.8	88.2808	67.1027
2015	7	29	1	33	24	0.3	3.9	0.82	95.5	88.2808	68.4835

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	29	1	43	24	0.3	3.9	0.77	98.1	88.2152	64.0155
2015	7	29	1	53	24	0.3	3.9	0.78	97.5	88.2808	64.8936
2015	7	29	2	3	24	0.3	3.9	0.77	97.1	88.2152	64.0155
2015	7	29	2	13	24	0.3	3.9	0.77	97.8	88.2152	64.5674
2015	7	29	2	23	24	0.3	3.9	0.82	97.4	88.2152	68.1545
2015	7	29	2	33	24	0.3	3.9	0.77	95.9	88.2152	64.0156
2015	7	29	2	43	24	0.3	3.9	0.82	98.1	88.2152	67.8786
2015	7	29	2	53	24	0.3	3.9	0.76	94.9	88.2152	64.0157
2015	7	29	3	3	24	0.3	3.9	0.77	97.9	88.2152	63.7397
2015	7	29	3	13	24	0.3	3.9	0.76	95.4	88.2152	63.7398
2015	7	29	3	23	24	0.3	3.9	0.78	96.1	88.2152	64.8435
2015	7	29	3	33	24	0.3	3.9	0.82	95.3	88.1496	68.929
2015	7	29	3	43	24	0.3	3.9	0.77	97.1	88.1496	64.2418
2015	7	29	3	53	24	0.3	3.9	0.81	98.2	88.1496	67.2747
2015	7	29	4	3	24	0.3	3.9	0.8	94.9	88.1496	66.999
2015	7	29	4	13	24	0.3	3.9	0.76	98.2	88.1496	62.8633
2015	7	29	4	23	24	0.3	3.9	0.79	95.7	88.1496	66.4476
2015	7	29	4	33	24	0.3	3.9	0.75	96.1	88.1496	62.3119
2015	7	29	4	43	24	0.3	3.9	0.79	96.9	88.1496	65.6205
2015	7	29	4	53	24	0.3	3.9	0.81	98.6	88.1496	67.2748
2015	7	29	5	3	24	0.3	3.9	0.77	97.1	88.1496	64.242
2015	7	29	5	13	24	0.3	3.9	0.79	97.6	88.1496	66.172
2015	7	29	5	23	24	0.3	3.9	0.78	96.5	88.084	65.2942
2015	7	29	5	33	24	0.3	3.9	0.82	96.4	88.084	68.3247
2015	7	29	5	43	24	0.3	3.9	0.77	96.2	88.084	63.9167
2015	7	29	5	53	24	0.3	3.9	0.79	97.2	88.084	65.8452
2015	7	29	6	3	24	0.3	3.9	0.79	95.2	88.084	66.1208
2015	7	29	6	13	24	0.3	3.9	0.75	96.3	88.084	62.2637
2015	7	29	6	23	24	0.3	3.9	0.78	97.2	88.084	65.2943
2015	7	29	6	33	24	0.3	3.9	0.82	97.1	88.084	68.3249
2015	7	29	6	43	24	0.3	3.9	0.81	96.5	88.084	67.4984
2015	7	29	6	53	24	0.3	3.9	0.8	96.2	88.084	66.3964
2015	7	29	7	3	24	0.3	3.9	0.8	94.2	88.084	66.9474
2015	7	29	7	13	24	0.3	3.9	0.76	98.2	88.0184	62.766
2015	7	29	7	23	24	0.3	3.9	0.78	98.7	88.0184	64.4178
2015	7	29	7	33	24	0.3	3.9	0.77	97.8	88.0184	64.4178
2015	7	29	7	43	24	0.3	3.9	0.82	96.2	88.0184	68.8224
2015	7	29	7	53	24	0.3	3.9	0.76	94.7	88.0184	63.8672
2015	7	29	8	3	24	0.3	3.9	0.76	96	88.0184	63.0413
2015	7	29	8	13	24	0.3	3.9	0.75	95	88.0184	63.0413
2015	7	29	8	23	24	0.3	3.9	0.78	95.8	88.0184	64.9684
2015	7	29	8	33	24	0.3	3.9	0.79	99.3	88.0184	65.7942
2015	7	29	8	43	24	0.3	3.9	0.84	94.5	87.9528	70.1442
2015	7	29	8	53	24	0.3	3.9	0.79	94.3	87.9528	66.2932
2015	7	29	9	3	24	0.3	3.9	0.79	96.9	87.9528	65.4679
2015	7	29	9	13	24	0.3	3.9	0.76	96.2	87.9528	62.9922
2015	7	29	9	23	24	0.3	3.9	0.79	96.9	87.9528	65.743

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	29	9	33	24	0.3	3.9	0.78	96.5	87.9528	65.1928
2015	7	29	9	43	24	0.3	3.9	0.77	97.1	87.8871	64.0426
2015	7	29	9	53	24	0.3	3.9	0.79	95.7	87.8871	66.2415
2015	7	29	10	3	24	0.3	3.9	0.76	96.7	87.8871	63.218
2015	7	29	10	13	24	0.3	3.9	0.8	96.8	87.8215	66.4645
2015	7	29	10	23	24	0.3	3.9	0.76	96.2	87.8215	63.4433
2015	7	29	10	33	24	0.3	3.9	0.77	97.1	87.6903	63.6186
2015	7	29	10	43	24	0.3	3.9	0.71	99.2	87.6247	58.9109
2015	7	29	10	53	24	0.3	3.9	0.76	97.2	87.5591	63.2454
2015	7	29	11	3	24	0.3	3.9	0.78	98.7	87.5591	64.3406
2015	7	29	11	13	24	0.3	3.9	0.77	98.1	87.5591	63.7929
2015	7	29	11	23	24	0.3	3.9	0.8	97.1	87.5591	66.257
2015	7	29	11	33	24	0.3	3.9	0.75	96.8	87.5591	62.1501
2015	7	29	11	43	24	0.3	3.9	0.77	97.4	87.4934	63.4694
2015	7	29	11	53	24	0.3	3.9	0.8	97.1	87.4934	66.2051
2015	7	29	12	3	24	0.3	3.9	0.76	96.9	87.4934	62.9222
2015	7	29	12	13	24	0.3	3.9	0.75	97.3	87.4934	62.1014
2015	7	29	12	23	24	0.3	3.9	0.76	97.4	87.4278	63.1463
2015	7	29	12	33	24	0.3	3.9	0.79	97.6	87.4278	65.3331
2015	7	29	12	43	24	0.3	3.9	0.78	97.2	87.4278	64.7863
2015	7	29	12	53	24	0.3	3.9	0.78	96.3	87.4278	64.2396
2015	7	29	13	3	24	0.3	3.9	0.75	94.7	87.4278	62.5994
2015	7	29	13	13	24	0.3	3.9	0.75	96.8	87.4278	62.0527
2015	7	29	13	23	24	0.3	3.9	0.73	96.4	87.4278	60.6858
2015	7	29	13	33	24	0.3	3.9	0.78	94.6	87.3622	65.0086
2015	7	29	13	43	24	0.3	3.9	0.72	97.1	87.3622	59.5457
2015	7	29	13	53	24	0.3	3.9	0.78	97.5	87.2966	64.1388
2015	7	29	14	3	24	0.3	3.9	0.73	98.8	87.3622	59.8188
2015	7	29	14	13	24	0.3	3.9	0.69	97.4	87.231	56.9978
2015	7	29	14	23	24	0.3	3.9	0.75	97.2	87.231	62.1794
2015	7	29	14	33	24	0.3	3.9	0.75	97.8	87.231	61.3612
2015	7	29	14	43	24	0.3	3.9	0.8	98.1	87.1654	65.4006
2015	7	29	14	53	24	0.3	3.9	0.76	96.2	87.0341	62.305
2015	7	29	15	3	24	0.3	3.9	0.72	96.5	87.0341	59.5843
2015	7	29	15	13	24	0.3	3.9	0.73	95.9	86.9685	60.353
2015	7	29	15	23	24	0.3	3.9	0.78	98	86.9029	63.8368
2015	7	29	15	33	24	0.3	3.9	0.76	96.2	86.9029	62.2069
2015	7	29	15	43	24	0.3	3.9	0.73	97	86.8373	59.9864
2015	7	29	15	53	24	0.3	3.9	0.75	96.1	86.9029	61.3919
2015	7	29	16	3	24	0.3	3.9	0.75	96.8	86.8373	61.8864
2015	7	29	16	13	24	0.3	3.9	0.79	96.2	86.8373	64.8722
2015	7	29	16	23	24	0.3	3.9	0.75	97.7	86.7717	61.8376
2015	7	29	16	33	24	0.3	3.9	0.76	98	86.7717	61.8376
2015	7	29	16	43	24	0.3	3.9	0.77	96.9	86.7717	62.9225
2015	7	29	16	53	24	0.3	3.9	0.75	97.8	86.7717	61.0239
2015	7	29	17	3	24	0.3	3.9	0.77	96.8	86.7717	63.4649
2015	7	29	17	13	24	0.3	3.9	0.75	95.8	86.7717	61.5664

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	29	17	23	24	0.3	3.9	0.77	96.3	86.706	63.4148
2015	7	29	17	33	24	0.3	3.9	0.74	96.4	86.706	60.7048
2015	7	29	17	43	24	0.3	3.9	0.73	99.6	86.706	59.0788
2015	7	29	17	53	24	0.3	3.9	0.76	97.2	86.706	62.6018
2015	7	29	18	3	24	0.3	3.9	0.79	97.7	86.706	64.4988
2015	7	29	18	13	24	0.3	3.9	0.71	96.6	86.706	58.2658
2015	7	29	18	23	24	0.3	3.9	0.74	97.4	86.6404	60.3886
2015	7	29	18	33	24	0.3	3.9	0.74	94.1	86.5748	60.6089
2015	7	29	18	43	24	0.3	3.9	0.73	96.4	86.5748	60.0678
2015	7	29	18	53	24	0.3	3.9	0.76	96.5	86.5748	61.9618
2015	7	29	19	3	24	0.3	3.9	0.69	95.7	86.5092	56.5055
2015	7	29	19	13	24	0.3	3.9	0.74	97.1	86.4436	60.513
2015	7	29	19	23	24	0.3	3.9	0.72	94.7	86.5092	59.4795
2015	7	29	19	33	24	0.3	3.9	0.81	94.6	86.4436	66.4563
2015	7	29	19	43	24	0.3	3.9	0.75	91.2	86.378	62.0847
2015	7	29	19	53	24	0.3	3.9	0.79	92.4	86.378	65.3239
2015	7	29	20	3	24	0.3	3.9	0.82	93.7	86.4436	67.2667
2015	7	29	20	13	24	0.3	3.9	0.75	91.8	86.3123	61.496
2015	7	29	20	23	24	0.3	3.9	0.73	96	86.4436	59.4324
2015	7	29	20	33	24	0.3	3.9	0.75	99.9	86.5748	60.6089
2015	7	29	20	43	24	0.3	3.9	0.81	96.1	86.5748	66.0204
2015	7	29	20	53	24	0.3	3.9	0.74	97.9	86.5092	60.0202
2015	7	29	21	3	24	0.3	3.9	0.72	97.8	86.5092	58.9388
2015	7	29	21	13	24	0.3	3.9	0.71	96.9	86.4436	57.8116
2015	7	29	21	23	24	0.3	3.9	0.76	95.7	86.4436	62.1339
2015	7	29	21	33	24	0.3	3.9	0.73	96.2	86.4436	59.7026
2015	7	29	21	43	24	0.3	3.9	0.74	97.6	86.4436	60.7832
2015	7	29	21	53	24	0.3	3.9	0.73	97.7	86.4436	59.9728
2015	7	29	22	3	24	0.3	3.9	0.78	95.5	86.378	63.9743
2015	7	29	22	13	24	0.3	3.9	0.74	98.1	86.378	60.4651
2015	7	29	22	23	24	0.3	3.9	0.75	98.3	86.378	61.2749
2015	7	29	22	33	24	0.3	3.9	0.77	96.9	86.378	62.8945
2015	7	29	22	43	24	0.3	3.9	0.79	96.5	86.378	64.2442
2015	7	29	22	53	24	0.3	3.9	0.77	97.4	86.378	62.6246
2015	7	29	23	3	24	0.3	3.9	0.75	96	86.378	61.5449
2015	7	29	23	13	24	0.3	3.9	0.73	96.2	86.3123	59.6081
2015	7	29	23	23	24	0.3	3.9	0.77	96.1	86.3123	62.8447
2015	7	29	23	33	24	0.3	3.9	0.74	99	86.378	59.9253
2015	7	29	23	43	24	0.3	3.9	0.75	95	86.3123	61.7658
2015	7	29	23	53	24	0.3	3.9	0.72	98.9	86.3123	58.7989
2015	7	30	0	3	24	0.3	3.9	0.75	101.3	86.3123	60.687
2015	7	30	0	13	24	0.3	3.9	0.75	98.6	86.3123	60.687
2015	7	30	0	23	24	0.3	3.9	0.74	96.4	86.3123	60.4173
2015	7	30	0	33	24	0.3	3.9	0.76	97.5	86.3123	61.7659
2015	7	30	0	43	24	0.3	3.9	0.78	99.7	86.3123	62.8448
2015	7	30	0	53	24	0.3	3.9	0.75	95	86.2467	61.4474
2015	7	30	1	3	24	0.3	3.9	0.79	99.3	86.2467	64.1424

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	30	1	13	24	0.3	3.9	0.74	97.1	86.2467	60.3694
2015	7	30	1	23	24	0.3	3.9	0.73	98	86.2467	59.2913
2015	7	30	1	33	24	0.3	3.9	0.79	95.7	86.2467	64.412
2015	7	30	1	43	24	0.3	3.9	0.75	98.3	86.2467	60.6389
2015	7	30	1	53	24	0.3	3.9	0.75	97.3	86.2467	60.9084
2015	7	30	2	3	24	0.3	3.9	0.77	98.1	86.2467	62.795
2015	7	30	2	13	24	0.3	3.9	0.79	98.1	86.2467	64.412
2015	7	30	2	23	24	0.3	3.9	0.75	96.1	86.2467	60.9084
2015	7	30	2	33	24	0.3	3.9	0.77	95.4	86.3123	62.8448
2015	7	30	2	43	24	0.3	3.9	0.78	96.8	86.2467	63.334
2015	7	30	2	53	24	0.3	3.9	0.79	97.2	86.2467	64.1425
2015	7	30	3	3	24	0.3	3.9	0.77	94.7	86.2467	62.795
2015	7	30	3	13	24	0.3	3.9	0.76	98.4	86.2467	61.717
2015	7	30	3	23	24	0.3	3.9	0.78	96.1	86.2467	63.334
2015	7	30	3	33	24	0.3	3.9	0.78	96.3	86.2467	63.8731
2015	7	30	3	43	24	0.3	3.9	0.75	95	86.2467	61.717
2015	7	30	3	53	24	0.3	3.9	0.74	96.4	86.2467	60.3695
2015	7	30	4	3	24	0.3	3.9	0.76	96.7	86.2467	62.2561
2015	7	30	4	13	24	0.3	3.9	0.81	96.8	86.2467	66.0292
2015	7	30	4	23	24	0.3	3.9	0.75	97.3	86.2467	60.9086
2015	7	30	4	33	24	0.3	3.9	0.78	94.8	86.2467	64.1427
2015	7	30	4	43	24	0.3	3.9	0.8	95.6	86.2467	65.4902
2015	7	30	4	53	24	0.3	3.9	0.83	97.9	86.2467	67.9158
2015	7	30	5	3	24	0.3	3.9	0.73	96.5	86.3123	59.6084
2015	7	30	5	13	24	0.3	3.9	0.79	99.3	86.2467	63.8732
2015	7	30	5	23	24	0.3	3.9	0.75	97.3	86.3123	61.2267
2015	7	30	5	33	24	0.3	3.9	0.77	96.6	86.3123	63.1148
2015	7	30	5	43	24	0.3	3.9	0.8	93.3	86.2467	65.4903
2015	7	30	5	53	24	0.3	3.9	0.76	95.7	86.3123	62.0359
2015	7	30	6	3	24	0.3	3.9	0.75	96.3	86.3123	61.2268
2015	7	30	6	13	24	0.3	3.9	0.78	95.5	86.3123	64.1937
2015	7	30	6	23	24	0.3	3.9	0.78	96.1	86.3123	63.3846
2015	7	30	6	33	24	0.3	3.9	0.75	97.3	86.3123	61.2268
2015	7	30	6	43	24	0.3	3.9	0.76	96.2	86.3123	62.036
2015	7	30	6	53	24	0.3	3.9	0.8	98.7	86.3123	65.2726
2015	7	30	7	3	24	0.3	3.9	0.78	97	86.3123	63.3846
2015	7	30	7	13	24	0.3	3.9	0.8	95.7	86.3123	65.2727
2015	7	30	7	23	24	0.3	3.9	0.79	98.4	86.378	63.9748
2015	7	30	7	33	24	0.3	3.9	0.73	98.7	86.3123	59.6085
2015	7	30	8	1	37	0.3	3.9	0.78	98.9	86.3123	63.6543
2015	7	30	8	23	16	0.3	3.9	0.78	97.7	86.378	63.7048
2015	7	30	8	33	16	0.3	3.9	0.8	95.9	86.378	65.3244
2015	7	30	8	43	16	0.3	3.9	0.78	94.3	86.378	64.2447
2015	7	30	8	53	16	0.3	3.9	0.75	97.8	86.378	60.7355
2015	7	30	9	3	16	0.3	3.9	0.75	97.8	86.378	60.7354
2015	7	30	9	13	16	0.3	3.9	0.76	95.7	86.3123	62.5754
2015	7	30	9	23	16	0.3	3.9	0.73	97.5	86.3123	59.6084

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	30	9	33	16	0.3	3.9	0.78	99.9	86.3123	63.3845
2015	7	30	9	43	16	0.3	3.9	0.82	98.1	86.3123	66.3515
2015	7	30	9	53	16	0.3	3.9	0.8	98	86.3123	65.0028
2015	7	30	10	3	16	0.3	3.9	0.76	95.7	86.2467	62.5257
2015	7	30	10	13	16	0.3	3.9	0.77	96.6	86.3123	62.5753
2015	7	30	10	23	16	0.3	3.9	0.76	96.2	86.2467	61.7171
2015	7	30	10	33	16	0.3	3.9	0.74	97.4	86.2467	60.3695
2015	7	30	10	43	16	0.3	3.9	0.76	96.9	86.1811	61.9373
2015	7	30	10	53	16	0.3	3.9	0.75	97.3	86.1811	60.8601
2015	7	30	11	3	16	0.3	3.9	0.76	98.4	86.1811	61.9373
2015	7	30	11	13	16	0.3	3.9	0.75	98.6	86.1155	60.8118
2015	7	30	11	23	16	0.3	3.9	0.78	94.8	86.1155	64.0407
2015	7	30	11	33	16	0.3	3.9	0.78	95.3	86.1155	64.0407
2015	7	30	11	43	16	0.3	3.9	0.77	96.1	86.1155	62.6953
2015	7	30	11	53	16	0.3	3.9	0.72	99.1	86.1155	58.6591
2015	7	30	12	3	16	0.3	3.9	0.74	97.4	86.1155	60.2736
2015	7	30	12	13	16	0.3	3.9	0.73	99	86.1155	59.4663
2015	7	30	12	23	16	0.3	3.9	0.76	96.9	86.1155	61.888
2015	7	30	12	33	16	0.3	3.9	0.79	98.1	86.1155	64.0406
2015	7	30	12	43	16	0.3	3.9	0.76	97.4	86.1155	62.157
2015	7	30	12	53	16	0.3	3.9	0.72	95.8	86.1155	58.659
2015	7	30	13	3	16	0.3	3.9	0.73	97.8	86.1155	58.928
2015	7	30	13	13	16	0.3	3.9	0.76	98.4	86.1155	61.6188
2015	7	30	13	23	16	0.3	3.9	0.74	96.6	86.1155	60.2734
2015	7	30	13	33	16	0.3	3.9	0.76	96.7	86.1155	62.1569
2015	7	30	13	43	16	0.3	3.9	0.78	99.5	86.1155	62.6951
2015	7	30	13	53	16	0.3	3.9	0.75	95	86.1155	61.6187
2015	7	30	14	3	16	0.3	3.9	0.74	94.8	86.1155	60.8114
2015	7	30	14	13	16	0.3	3.9	0.75	97	86.0499	61.0319
2015	7	30	14	23	16	0.3	3.9	0.75	96.3	86.1155	61.3495
2015	7	30	14	33	16	0.3	3.9	0.76	96.2	86.1155	61.8876
2015	7	30	14	43	16	0.3	3.9	0.79	95.7	86.0499	64.2582
2015	7	30	14	53	16	0.3	3.9	0.75	96.8	86.0499	60.763
2015	7	30	15	3	16	0.3	3.9	0.77	96.1	86.0499	62.9139
2015	7	30	15	13	16	0.3	3.9	0.71	99.2	86.0499	57.8055
2015	7	30	15	23	16	0.3	3.9	0.75	97.5	86.0499	61.0318
2015	7	30	15	33	16	0.3	3.9	0.71	98.5	86.0499	57.8055
2015	7	30	15	43	16	0.3	3.9	0.71	99.3	86.0499	57.5366
2015	7	30	15	53	16	0.3	3.9	0.74	94.8	86.0499	60.4941
2015	7	30	16	3	16	0.3	3.9	0.73	96.7	85.9843	59.1027
2015	7	30	16	13	16	0.3	3.9	0.74	96.9	86.0499	59.9564
2015	7	30	16	23	16	0.3	3.9	0.76	96.7	86.0499	61.8384
2015	7	30	16	33	16	0.3	3.9	0.71	96.7	85.9843	57.4908
2015	7	30	16	43	16	0.3	3.9	0.74	96.9	86.0499	59.9564
2015	7	30	16	53	16	0.3	3.9	0.76	94.4	86.0499	62.3761
2015	7	30	17	3	16	0.3	3.9	0.73	97.5	85.9843	59.3713
2015	7	30	17	13	16	0.3	3.9	0.73	96.5	85.9843	59.1027

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	30	17	23	16	0.3	3.9	0.75	98.1	85.9843	60.4459
2015	7	30	17	33	16	0.3	3.9	0.75	98.8	85.9843	60.7146
2015	7	30	17	43	16	0.3	3.9	0.74	95.1	85.9843	60.1773
2015	7	30	17	53	16	0.3	3.9	0.74	96.8	85.9843	60.4459
2015	7	30	18	3	16	0.3	3.9	0.78	96.3	85.9843	63.1324
2015	7	30	18	13	16	0.3	3.9	0.75	97	85.9843	60.9832
2015	7	30	18	23	16	0.3	3.9	0.78	98.3	85.9843	62.8637
2015	7	30	18	33	16	0.3	3.9	0.79	97.8	85.9843	64.4756
2015	7	30	18	43	16	0.3	3.9	0.73	97.8	85.9843	59.1027
2015	7	30	18	53	16	0.3	3.9	0.75	97.8	85.9843	60.4459
2015	7	30	19	3	16	0.3	3.9	0.77	96.9	85.9843	62.3264
2015	7	30	19	13	16	0.3	3.9	0.77	97.5	85.9843	62.8637
2015	7	30	19	23	16	0.3	3.9	0.76	95.7	85.9843	61.7892
2015	7	30	19	33	16	0.3	3.9	0.78	95.8	85.9843	63.401
2015	7	30	19	43	16	0.3	3.9	0.77	94.9	85.9843	62.8638
2015	7	30	19	53	16	0.3	3.9	0.76	97.4	85.9843	62.0578
2015	7	30	20	3	16	0.3	3.9	0.76	96	85.9843	61.7892
2015	7	30	20	13	16	0.3	3.9	0.76	96.7	86.0499	61.8384
2015	7	30	20	23	16	0.3	3.9	0.75	97.3	86.0499	60.763
2015	7	30	20	33	16	0.3	3.9	0.78	97.5	86.0499	63.7204
2015	7	30	20	43	16	0.3	3.9	0.76	98.4	85.9843	61.5205
2015	7	30	20	53	16	0.3	3.9	0.76	97.2	85.9843	62.0578
2015	7	30	21	3	16	0.3	3.9	0.72	95.7	86.0499	58.8809
2015	7	30	21	13	16	0.3	3.9	0.78	95.8	86.0499	63.4516
2015	7	30	21	23	16	0.3	3.9	0.8	98.1	86.0499	64.5271
2015	7	30	21	33	16	0.3	3.9	0.75	97.6	86.0499	60.763
2015	7	30	21	43	16	0.3	3.9	0.77	94.7	86.0499	62.645
2015	7	30	21	53	16	0.3	3.9	0.78	98.2	86.0499	63.4516
2015	7	30	22	3	16	0.3	3.9	0.79	95.5	86.0499	64.2582
2015	7	30	22	13	16	0.3	3.9	0.78	97.2	86.0499	63.7205
2015	7	30	22	23	16	0.3	3.9	0.75	94.5	86.0499	61.5696
2015	7	30	22	33	16	0.3	3.9	0.76	95.2	86.0499	62.3762
2015	7	30	22	43	16	0.3	3.9	0.76	97.5	86.0499	61.5696
2015	7	30	22	53	16	0.3	3.9	0.76	97.5	86.0499	61.5696
2015	7	30	23	3	16	0.3	3.9	0.77	95.9	86.0499	62.914
2015	7	30	23	13	16	0.3	3.9	0.76	98.4	86.0499	61.5697
2015	7	30	23	23	16	0.3	3.9	0.76	96.9	86.0499	61.8385
2015	7	30	23	33	16	0.3	3.9	0.77	97.8	86.0499	62.6451
2015	7	30	23	43	16	0.3	3.9	0.81	97.7	86.0499	65.6026
2015	7	30	23	53	16	0.3	3.9	0.73	96.7	86.0499	59.1499
2015	7	31	0	3	16	0.3	3.9	0.75	95.5	86.0499	61.3008
2015	7	31	0	13	16	0.3	3.9	0.78	97.2	86.0499	63.7206
2015	7	31	0	23	16	0.3	3.9	0.81	98	86.0499	65.3338
2015	7	31	0	33	16	0.3	3.9	0.76	98.2	86.0499	61.8386
2015	7	31	0	43	16	0.3	3.9	0.77	97.6	86.0499	62.3763
2015	7	31	0	53	16	0.3	3.9	0.77	98.8	86.0499	62.3763
2015	7	31	1	3	16	0.3	3.9	0.76	96.7	86.0499	61.5698

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	31	1	13	16	0.3	3.9	0.77	98.4	86.0499	62.1075
2015	7	31	1	23	16	0.3	3.9	0.75	97.3	86.0499	60.7632
2015	7	31	1	33	16	0.3	3.9	0.79	97.8	86.0499	64.5273
2015	7	31	1	43	16	0.3	3.9	0.77	94.2	86.0499	62.6452
2015	7	31	1	53	16	0.3	3.9	0.76	95.7	86.0499	61.5698
2015	7	31	2	3	16	0.3	3.9	0.77	97.3	86.0499	62.9141
2015	7	31	2	13	16	0.3	3.9	0.74	98.7	86.0499	59.9566
2015	7	31	2	23	16	0.3	3.9	0.8	96.4	86.0499	64.7962
2015	7	31	2	33	16	0.3	3.9	0.78	96.3	86.0499	63.7207
2015	7	31	2	43	16	0.3	3.9	0.75	96.8	86.0499	60.7632
2015	7	31	2	53	16	0.3	3.9	0.76	96.7	86.0499	61.5698
2015	7	31	3	3	16	0.3	3.9	0.78	98.3	86.0499	62.9142
2015	7	31	3	13	16	0.3	3.9	0.77	97.4	86.0499	62.3764
2015	7	31	3	23	16	0.3	3.9	0.78	96	86.0499	63.4519
2015	7	31	3	33	16	0.3	3.9	0.79	98.4	86.0499	63.9896
2015	7	31	3	43	16	0.3	3.9	0.77	94.6	86.0499	62.9142
2015	7	31	3	53	16	0.3	3.9	0.73	97.2	86.0499	59.6878
2015	7	31	4	3	16	0.3	3.9	0.78	97.2	86.0499	63.4519
2015	7	31	4	13	16	0.3	3.9	0.76	96.7	86.0499	61.5699
2015	7	31	4	23	16	0.3	3.9	0.79	97.2	86.1155	64.0406
2015	7	31	4	33	16	0.3	3.9	0.78	96.3	86.1155	63.7715
2015	7	31	4	43	16	0.3	3.9	0.77	98.5	86.1155	62.6952
2015	7	31	4	53	16	0.3	3.9	0.8	96.8	86.1155	65.386
2015	7	31	5	3	16	0.3	3.9	0.75	97	86.1155	61.0807
2015	7	31	5	13	16	0.3	3.9	0.79	97.8	86.1155	64.5788
2015	7	31	5	23	16	0.3	3.9	0.79	97.9	86.1155	63.7715
2015	7	31	5	33	16	0.3	3.9	0.74	96.9	86.1155	60.2735
2015	7	31	5	43	16	0.3	3.9	0.75	97.5	86.1155	61.3499
2015	7	31	5	53	16	0.3	3.9	0.78	95	86.1155	64.0407
2015	7	31	6	3	16	0.3	3.9	0.8	94.5	86.1155	65.386
2015	7	31	6	13	16	0.3	3.9	0.73	96.7	86.1155	59.1972
2015	7	31	6	23	16	0.3	3.9	0.77	95.6	86.1155	62.6953
2015	7	31	6	33	16	0.3	3.9	0.77	95.9	86.1155	62.6953
2015	7	31	6	43	16	0.3	3.9	0.77	95.6	86.1155	63.2334
2015	7	31	6	53	16	0.3	3.9	0.73	96.7	86.1155	59.1973
2015	7	31	7	3	16	0.3	3.9	0.77	95.1	86.1155	63.2334
2015	7	31	7	13	16	0.3	3.9	0.77	96.1	86.1155	62.6953
2015	7	31	7	23	16	0.3	3.9	0.76	97.2	86.1155	62.1571
2015	7	31	7	33	16	0.3	3.9	0.77	96.2	86.1155	62.4262
2015	7	31	7	43	16	0.3	3.9	0.76	98.4	86.1155	61.619
2015	7	31	7	53	16	0.3	3.9	0.75	95.3	86.1155	61.0808
2015	7	31	8	3	16	0.3	3.9	0.78	95.3	86.1155	63.5025
2015	7	31	8	13	16	0.3	3.9	0.78	96.7	86.1155	63.7716
2015	7	31	8	23	16	0.3	3.9	0.77	96.9	86.1155	62.4262
2015	7	31	8	33	16	0.3	3.9	0.77	95.2	86.1155	62.6953
2015	7	31	8	43	16	0.3	3.9	0.75	96.3	86.1155	60.8117
2015	7	31	8	53	16	0.3	3.9	0.74	98.1	86.1155	60.2736

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	31	9	3	16	0.3	3.9	0.81	95.5	86.1155	66.4624
2015	7	31	9	13	16	0.3	3.9	0.74	97.7	86.1155	60.0045
2015	7	31	9	23	16	0.3	3.9	0.73	94.1	86.1155	59.7354
2015	7	31	9	33	16	0.3	3.9	0.77	96.9	86.1155	62.6953
2015	7	31	9	43	16	0.3	3.9	0.76	94.9	86.1155	62.1571
2015	7	31	9	53	16	0.3	3.9	0.8	95.7	86.1155	65.117
2015	7	31	10	3	16	0.3	3.9	0.72	97.5	86.1155	58.9282
2015	7	31	10	13	16	0.3	3.9	0.77	96.1	86.1155	62.9643
2015	7	31	10	23	16	0.3	3.9	0.8	96.3	86.1155	65.386
2015	7	31	10	33	16	0.3	3.9	0.81	96.1	86.1155	65.9241
2015	7	31	10	43	16	0.3	3.9	0.78	94.6	86.1155	64.0406
2015	7	31	10	53	16	0.3	3.9	0.79	95.3	86.1155	64.3097
2015	7	31	11	3	16	0.3	3.9	0.77	97.8	86.1155	62.6952
2015	7	31	11	13	16	0.3	3.9	0.75	97.5	86.1155	61.3498
2015	7	31	11	23	16	0.3	3.9	0.78	96.1	86.1155	63.2333
2015	7	31	11	33	16	0.3	3.9	0.77	98.3	86.1155	62.4261
2015	7	31	11	43	16	0.3	3.9	0.75	95	86.0499	61.301
2015	7	31	11	53	16	0.3	3.9	0.76	94.9	86.0499	62.1076
2015	7	31	12	3	16	0.3	3.9	0.72	92.6	86.0499	58.8812
2015	7	31	12	13	16	0.3	3.9	0.78	97.7	86.0499	63.4519
2015	7	31	12	23	16	0.3	3.9	0.78	98.3	86.0499	62.9141
2015	7	31	12	33	16	0.3	3.9	0.77	97.8	86.0499	62.6452
2015	7	31	12	43	16	0.3	3.9	0.76	95.7	86.0499	62.3763
2015	7	31	12	53	16	0.3	3.9	0.76	96.9	86.0499	61.8386
2015	7	31	13	3	16	0.3	3.9	0.77	97.6	86.0499	62.3763
2015	7	31	13	13	16	0.3	3.9	0.76	96.2	86.0499	61.8386
2015	7	31	13	23	16	0.3	3.9	0.72	96.1	86.0499	58.3433
2015	7	31	13	33	16	0.3	3.9	0.78	98.2	86.0499	63.4517
2015	7	31	13	43	16	0.3	3.9	0.74	96.6	86.0499	60.4941
2015	7	31	13	53	16	0.3	3.9	0.77	95.6	86.0499	62.9139
2015	7	31	14	3	16	0.3	3.9	0.77	97.1	86.0499	62.6451
2015	7	31	14	13	16	0.3	3.9	0.77	97.6	86.0499	62.3762
2015	7	31	14	23	16	0.3	3.9	0.75	96.8	86.0499	60.763
2015	7	31	14	33	16	0.3	3.9	0.76	97.4	86.0499	61.8384
2015	7	31	14	43	16	0.3	3.9	0.77	97.3	86.0499	62.9139
2015	7	31	14	53	16	0.3	3.9	0.76	97.4	86.0499	62.1072
2015	7	31	15	3	16	0.3	3.9	0.74	95.4	86.0499	60.2251
2015	7	31	15	13	16	0.3	3.9	0.77	97.3	86.0499	62.9137
2015	7	31	15	23	16	0.3	3.9	0.77	95.3	86.0499	63.1826
2015	7	31	15	33	16	0.3	3.9	0.79	95.5	86.0499	64.258
2015	7	31	15	43	16	0.3	3.9	0.74	95.3	85.9843	60.4458
2015	7	31	15	53	16	0.3	3.9	0.75	99.3	85.9843	60.7144
2015	7	31	16	3	16	0.3	3.9	0.78	96.1	85.9843	63.1323
2015	7	31	16	13	16	0.3	3.9	0.7	97.8	85.9843	56.6847
2015	7	31	16	23	16	0.3	3.9	0.76	97.5	85.9843	61.5204
2015	7	31	16	33	16	0.3	3.9	0.75	95	85.9843	61.5204
2015	7	31	16	43	16	0.3	3.9	0.77	96.3	85.9843	62.8636

Reinhackle (0356)

Year	Month	Day	Hour	Minute	Second	CellBegin	CellEnd	Speed	Direction	Area	Flow
2015	7	31	16	53	16	0.3	3.9	0.78	97.3	85.9843	63.1322
2015	7	31	17	3	16	0.3	3.9	0.79	95.9	85.9843	64.4755
2015	7	31	17	13	16	0.3	3.9	0.78	95.1	85.9843	63.6695
2015	7	31	17	23	16	0.3	3.9	0.79	94.5	85.9843	64.7441
2015	7	31	17	33	16	0.3	3.9	0.75	96.1	85.9186	60.666
2015	7	31	17	43	16	0.3	3.9	0.79	98.4	85.9186	63.6188
2015	7	31	17	53	16	0.3	3.9	0.74	95.6	85.9186	60.666
2015	7	31	18	3	16	0.3	3.9	0.75	96.3	85.9186	61.2029
2015	7	31	18	13	16	0.3	3.9	0.79	94.8	85.9186	64.4241
2015	7	31	18	23	16	0.3	3.9	0.76	97.4	85.9186	61.7398
2015	7	31	18	33	16	0.3	3.9	0.75	98.3	85.9186	60.3976
2015	7	31	18	43	16	0.3	3.9	0.75	97.6	85.9186	60.666
2015	7	31	18	53	16	0.3	3.9	0.74	96.8	85.9186	60.3976
2015	7	31	19	3	16	0.3	3.9	0.75	96.3	85.9186	60.666
2015	7	31	19	13	16	0.3	3.9	0.75	98.8	85.9186	60.3976
2015	7	31	19	23	16	0.3	3.9	0.79	94.5	85.9186	64.1556
2015	7	31	19	33	16	0.3	3.9	0.79	98.1	85.9186	63.8872
2015	7	31	19	43	16	0.3	3.9	0.75	96	85.9186	61.2029
2015	7	31	19	53	16	0.3	3.9	0.76	96	85.9186	61.7397
2015	7	31	20	3	16	0.3	3.9	0.74	97.9	85.9186	59.5923
2015	7	31	20	13	16	0.3	3.9	0.78	97.2	85.9186	63.6188
2015	7	31	20	23	16	0.3	3.9	0.76	96.2	85.9186	61.7397
2015	7	31	20	33	16	0.3	3.9	0.74	97.7	85.9186	59.8607
2015	7	31	20	43	16	0.3	3.9	0.79	96.4	85.9186	64.4241
2015	7	31	20	53	16	0.3	3.9	0.76	96.2	85.9186	61.4713
2015	7	31	21	3	16	0.3	3.9	0.78	96.1	85.9186	63.0819
2015	7	31	21	13	16	0.3	3.9	0.75	96.8	85.9186	61.2029
2015	7	31	21	23	16	0.3	3.9	0.77	95.3	85.9186	63.0819
2015	7	31	21	33	16	0.3	3.9	0.75	95	85.9186	61.2029
2015	7	31	21	43	16	0.3	3.9	0.76	96.2	85.9186	61.7398
2015	7	31	21	53	16	0.3	3.9	0.77	98.1	85.9186	62.2766
2015	7	31	22	3	16	0.3	3.9	0.76	99.2	85.9186	61.2029
2015	7	31	22	13	16	0.3	3.9	0.8	97.1	85.9186	64.6926
2015	7	31	22	23	16	0.3	3.9	0.75	95.2	85.9186	61.4714
2015	7	31	22	33	16	0.3	3.9	0.76	96.4	85.9186	61.7398
2015	7	31	22	43	16	0.3	3.9	0.8	97.8	85.9186	64.961
2015	7	31	22	53	16	0.3	3.9	0.76	95.7	85.9186	61.4714
2015	7	31	23	3	16	0.3	3.9	0.78	96.8	85.9186	63.082
2015	7	31	23	13	16	0.3	3.9	0.78	96.1	85.9186	63.082
2015	7	31	23	23	16	0.3	3.9	0.75	95.5	85.9843	61.2518
2015	7	31	23	33	16	0.3	3.9	0.79	95	85.9843	64.4756
2015	7	31	23	43	16	0.3	3.9	0.76	95	85.9843	61.7891
2015	7	31	23	53	16	0.3	3.9	0.8	95.7	85.9843	65.0129

Alabama Gates Release

Station 0087

Date	Flow (cfs)
7/1/2015	23.942
7/2/2015	26.998
7/3/2015	21.721
7/4/2015	16.615
7/5/2015	18.393
7/6/2015	6.653
7/7/2015	0
7/8/2015	0
7/9/2015	0
7/10/2015	0
7/11/2015	0
7/12/2015	0
7/13/2015	0
7/14/2015	0
7/15/2015	0
7/16/2015	0
7/17/2015	0
7/18/2015	0
7/19/2015	0
7/20/2015	0
7/21/2015	0
7/22/2015	0
7/23/2015	0
7/24/2015	0
7/25/2015	0
7/26/2015	0
7/27/2015	0
7/28/2015	0
7/29/2015	0
7/30/2015	0
7/31/2015	0

Discharge Measurement Summary

Date Generated: Thu Jul 2 2015

File Information

File Name 150701LA.SPL.WAD
Start Date and Time 2015/07/01 08:09:25

Site Details

Site Name ALABAMA SPILL
Operator(s) MKH

System Information

Sensor Type FlowTracker
Serial # P2352
CPU Firmware Version 3.7
Software Ver 2.30
Mounting Correction 0.0%

Units (English Units)

Distance ft
Velocity ft/s
Area ft²
Discharge cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.2%	0.8%
Velocity	1.9%	4.0%
Width	0.1%	0.1%
Method	2.1%	-
# Stations	2.5%	-
Overall	3.9%	4.2%

Summary

Averaging Int.	40	# Stations	20
Start Edge	LEW	Total Width	19.000
Mean SNR	51.0 dB	Total Area	17.926
Mean Temp	68.63 °F	Mean Depth	0.943
Disch. Equation	Mid-Section	Mean Velocity	1.2830
		Total Discharge	22.9999

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	08:09	4.00	None	0.850	0.0	0.0	0.0000	1.00	0.8028	0.425	0.3412	1.5
1	08:09	5.00	0.6	1.000	0.6	0.400	0.8028	1.00	0.8028	1.000	0.8028	3.5
2	08:10	6.00	0.6	1.150	0.6	0.460	1.8599	1.00	1.8599	1.150	2.1388	9.3
3	08:11	7.00	0.6	1.200	0.6	0.480	2.0036	1.00	2.0036	1.200	2.4046	10.5
4	08:13	8.00	0.6	1.200	0.6	0.480	1.7405	1.00	1.7405	1.200	2.0888	9.1
5	08:14	9.00	0.6	1.200	0.6	0.480	1.4177	1.00	1.4177	1.200	1.7014	7.4
6	08:15	10.00	0.6	1.200	0.6	0.480	1.3976	1.00	1.3976	1.200	1.6773	7.3
7	08:16	11.00	0.6	1.150	0.6	0.460	1.9042	1.00	1.9042	1.150	2.1897	9.5
8	08:17	12.00	0.6	1.100	0.6	0.440	2.1998	1.00	2.1998	1.100	2.4199	10.5
9	08:18	13.00	0.6	1.000	0.6	0.400	2.4806	1.00	2.4806	1.000	2.4806	10.8
10	08:19	14.00	0.6	1.000	0.6	0.400	1.4003	1.00	1.4003	1.000	1.4003	6.1
11	08:20	15.00	0.6	0.950	0.6	0.380	0.8730	1.00	0.8730	0.950	0.8295	3.6
12	08:21	16.00	0.6	0.950	0.6	0.380	0.4731	1.00	0.4731	0.950	0.4495	2.0
13	08:22	17.00	0.6	0.950	0.6	0.380	0.3881	1.00	0.3881	0.950	0.3688	1.6
14	08:23	18.00	0.6	0.800	0.6	0.320	0.7375	1.00	0.7375	0.800	0.5899	2.6
15	08:24	19.00	0.6	0.800	0.6	0.320	0.5518	1.00	0.5518	0.800	0.4414	1.9
16	08:25	20.00	0.6	0.700	0.6	0.280	0.6142	1.00	0.6142	0.700	0.4300	1.9
17	08:26	21.00	0.6	0.600	0.6	0.240	0.1877	1.00	0.1877	0.600	0.1126	0.5
18	08:27	22.00	0.6	0.450	0.6	0.180	0.2411	1.00	0.2411	0.450	0.1085	0.5
19	08:27	23.00	None	0.200	0.0	0.0	0.0000	1.00	0.2411	0.100	0.0241	0.1

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary




Date Generated: Thu Jul 2 2015

File Information

File Name 150701LA.SPL.WAD
 Start Date and Time 2015/07/01 08:09:25

Site Details

Site Name ALABAMA SPILL
 Operator(s) MKH



Discharge Measurement Summary

Date Generated: Thu Jul 2 2015

File Information

File Name 150701LA.SPL.WAD
Start Date and Time 2015/07/01 08:09:25

Site Details

Site Name ALABAMA SPILL
Operator(s) MKH

Quality Control

St	Loc	%Dep	Message
2	6.00	0.6	High standard error: 0.117
3	7.00	0.6	High standard error: 0.128
4	8.00	0.6	High standard error: 0.127
5	9.00	0.6	High standard error: 0.109
6	10.00	0.6	High standard error: 0.105
7	11.00	0.6	High standard error: 0.138
8	12.00	0.6	High standard error: 0.118
10	14.00	0.6	High standard error: 0.148

Discharge Measurement Summary

Date Generated: Thu Jul 2 2015


File Information

File Name 150701LA.SPL.WAD
Start Date and Time 2015/07/01 08:09:25

Site Details

Site Name ALABAMA SPILL
Operator(s) MKH

Automatic Quality Control Test (BeamCheck)



Discharge Measurement Summary

Date Generated: Thu Jul 2 2015

File Information

File Name 150701LS.SPL.WAD
Start Date and Time 2015/07/01 13:55:36

Site Details

Site Name ALABAMA SPILL
Operator(s) MKH

System Information

Sensor Type FlowTracker
Serial # P2352
CPU Firmware Version 3.7
Software Ver 2.30
Mounting Correction 0.0%

Units (English Units)

Distance ft
Velocity ft/s
Area ft²
Discharge cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.2%	0.7%
Velocity	1.7%	5.4%
Width	0.1%	0.1%
Method	2.1%	-
# Stations	2.5%	-
Overall	3.8%	5.5%

Summary

Averaging Int.	40	# Stations	20
Start Edge	REW	Total Width	19.000
Mean SNR	48.1 dB	Total Area	17.725
Mean Temp	78.66 °F	Mean Depth	0.933
Disch. Equation	Mid-Section	Mean Velocity	1.3976
		Total Discharge	24.7734

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	13:55	4.00	None	0.850	0.0	0.0	0.0000	1.00	1.0056	0.425	0.4274	1.7
1	13:55	5.00	0.6	1.000	0.6	0.400	1.0056	1.00	1.0056	1.000	1.0056	4.1
2	13:56	6.00	0.6	1.150	0.6	0.460	1.9350	1.00	1.9350	1.150	2.2252	9.0
3	13:57	7.00	0.6	1.200	0.6	0.480	2.1982	1.00	2.1982	1.200	2.6381	10.6
4	13:58	8.00	0.6	1.200	0.6	0.480	1.6335	1.00	1.6335	1.200	1.9605	7.9
5	14:00	9.00	0.6	1.250	0.6	0.500	2.1184	1.00	2.1184	1.250	2.6480	10.7
6	14:01	10.00	0.6	1.200	0.6	0.480	1.7589	1.00	1.7589	1.200	2.1109	8.5
7	14:02	11.00	0.6	1.150	0.6	0.460	2.3002	1.00	2.3002	1.150	2.6451	10.7
8	14:03	12.00	0.6	1.050	0.6	0.420	1.9062	1.00	1.9062	1.050	2.0012	8.1
9	14:04	13.00	0.6	1.000	0.6	0.400	2.5846	1.00	2.5846	1.000	2.5846	10.4
10	14:05	14.00	0.6	1.000	0.6	0.400	1.4915	1.00	1.4915	1.000	1.4915	6.0
11	14:06	15.00	0.6	0.900	0.6	0.360	0.7933	1.00	0.7933	0.900	0.7139	2.9
12	14:07	16.00	0.6	0.900	0.6	0.360	0.5449	1.00	0.5449	0.900	0.4904	2.0
13	14:08	17.00	0.6	0.900	0.6	0.360	0.3097	1.00	0.3097	0.900	0.2787	1.1
14	14:09	18.00	0.6	0.800	0.6	0.320	0.6699	1.00	0.6699	0.800	0.5359	2.2
15	14:10	19.00	0.6	0.750	0.6	0.300	0.6040	1.00	0.6040	0.750	0.4530	1.8
16	14:11	20.00	0.6	0.700	0.6	0.280	0.4754	1.00	0.4754	0.700	0.3328	1.3
17	14:12	21.00	0.6	0.600	0.6	0.240	0.1755	1.00	0.1755	0.600	0.1053	0.4
18	14:14	22.00	0.6	0.450	0.6	0.180	0.2277	1.00	0.2277	0.450	0.1025	0.4
19	14:14	23.00	None	0.200	0.0	0.0	0.0000	1.00	0.2277	0.100	0.0228	0.1

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary




Date Generated: Thu Jul 2 2015

File Information

File Name 150701LS.SPL.WAD
 Start Date and Time 2015/07/01 13:55:36

Site Details

Site Name ALABAMA SPILL
 Operator(s) MKH



Discharge Measurement Summary

Date Generated: Thu Jul 2 2015

File Information

File Name 150701LS.SPL.WAD
Start Date and Time 2015/07/01 13:55:36

Site Details

Site Name ALABAMA SPILL
Operator(s) MKH

Quality Control

St	Loc	%Dep	Message
3	7.00	0.6	High standard error: 0.112
4	8.00	0.6	High standard error: 0.122
5	9.00	0.6	High standard error: 0.114
6	10.00	0.6	High standard error: 0.139
7	11.00	0.6	High standard error: 0.117
9	13.00	0.6	High standard error: 0.137
10	14.00	0.6	High standard error: 0.114
11	15.00	0.6	High SNR variation during measurement: 5.6,5.2

Discharge Measurement Summary

Date Generated: Wed Jul 15 2015

File Information

File Name 150702LA.SPL.WAD
Start Date and Time 2015/07/02 06:35:10

Site Details

Site Name ALABAMA SPILL
Operator(s) MKH

System Information

Sensor Type FlowTracker
Serial # P2352
CPU Firmware Version 3.7
Software Ver 2.30
Mounting Correction 0.0%

Units (English Units)

Distance ft
Velocity ft/s
Area ft²
Discharge cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.3%	2.1%
Velocity	0.8%	2.7%
Width	0.2%	0.2%
Method	2.3%	-
# Stations	2.5%	-
Overall	3.7%	3.5%

Summary

Averaging Int. 40 # Stations 20
Start Edge LEW Total Width 19.000
Mean SNR 47.2 dB Total Area 15.725
Mean Temp 70.69 °F Mean Depth 0.828
Disch. Equation Mid-Section Mean Velocity 1.8319
Total Discharge 28.8063

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	06:35	4.00	None	0.900	0.0	0.0	0.0000	1.00	1.0361	0.450	0.4662	1.6
1	06:35	5.00	0.6	0.900	0.6	0.360	1.0361	1.00	1.0361	0.900	0.9324	3.2
2	06:36	6.00	0.6	1.000	0.6	0.400	2.1142	1.00	2.1142	1.000	2.1142	7.3
3	06:37	7.00	0.6	1.000	0.6	0.400	2.7500	1.00	2.7500	1.000	2.7500	9.5
4	06:38	8.00	0.6	1.000	0.6	0.400	3.0197	1.00	3.0197	1.000	3.0197	10.5
5	06:39	9.00	0.6	1.000	0.6	0.400	3.5896	1.00	3.5896	1.000	3.5896	12.5
6	06:40	10.00	0.6	1.000	0.6	0.400	3.9383	1.00	3.9383	1.000	3.9383	13.7
7	06:41	11.00	0.6	0.950	0.6	0.380	3.8865	1.00	3.8865	0.950	3.6927	12.8
8	06:42	12.00	0.6	0.850	0.6	0.340	3.1093	1.00	3.1093	0.850	2.6431	9.2
9	06:43	13.00	0.6	0.750	0.6	0.300	2.7428	1.00	2.7428	0.750	2.0571	7.1
10	06:45	14.00	0.6	0.750	0.6	0.300	2.4665	1.00	2.4665	0.750	1.8499	6.4
11	06:46	15.00	0.6	0.600	0.6	0.240	0.9518	1.00	0.9518	0.600	0.5711	2.0
12	06:49	16.00	0.6	0.800	0.6	0.320	0.0722	1.00	0.0722	0.800	0.0577	0.2
13	06:51	17.00	0.6	1.000	0.6	0.400	0.0446	1.00	0.0446	1.000	0.0446	0.2
14	06:52	18.00	0.6	0.800	0.6	0.320	0.2877	1.00	0.2877	0.800	0.2301	0.8
15	06:53	19.00	0.6	0.800	0.6	0.320	0.4173	1.00	0.4173	0.800	0.3338	1.2
16	06:54	20.00	0.6	0.800	0.6	0.320	0.4534	1.00	0.4534	0.800	0.3627	1.3
17	06:55	21.00	0.6	0.650	0.6	0.260	0.1299	1.00	0.1299	0.650	0.0844	0.3
18	06:57	22.00	0.6	0.500	0.6	0.200	0.1099	1.00	0.1099	0.500	0.0550	0.2
19	06:57	23.00	None	0.250	0.0	0.0	0.0000	1.00	0.1099	0.125	0.0137	0.0

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary




Date Generated: Wed Jul 15 2015

File Information

File Name 150702LA.SPL.WAD
 Start Date and Time 2015/07/02 06:35:10

Site Details

Site Name ALABAMA SPILL
 Operator(s) MKH



Discharge Measurement Summary

Date Generated: Wed Jul 15 2015

File Information

File Name 150702LA.SPL.WAD
Start Date and Time 2015/07/02 06:35:10

Site Details

Site Name ALABAMA SPILL
Operator(s) MKH

Quality Control

St	Loc	%Dep	Message
12	16.00	0.6	High angle: 33
13	17.00	0.6	High angle: 48
18	22.00	0.6	SNR (36.3) is different from typical SNR (47.2)

Discharge Measurement Summary

Date Generated: Wed Jul 15 2015

File Information

File Name 150702AS.SPL.WAD
Start Date and Time 2015/07/02 13:37:33

Site Details

Site Name ALABAMA SPILL
Operator(s) MKH

System Information

Sensor Type FlowTracker
Serial # P2352
CPU Firmware Version 3.7
Software Ver 2.30
Mounting Correction 0.0%

Units (English Units)

Distance ft
Velocity ft/s
Area ft²
Discharge cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.4%	2.0%
Velocity	1.0%	3.9%
Width	0.2%	0.2%
Method	2.3%	-
# Stations	2.5%	-
Overall	3.7%	4.5%

Summary

Averaging Int.	40	# Stations	20
Start Edge	LEW	Total Width	19.000
Mean SNR	50.7 dB	Total Area	15.050
Mean Temp	80.24 °F	Mean Depth	0.792
Disch. Equation	Mid-Section	Mean Velocity	1.5697
		Total Discharge	23.6244

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	13:37	4.00	None	0.900	0.0	0.0	0.0000	1.00	1.1184	0.450	0.5033	2.1
1	13:37	5.00	0.6	0.850	0.6	0.340	1.1184	1.00	1.1184	0.850	0.9507	4.0
2	13:38	6.00	0.6	0.950	0.6	0.380	2.2198	1.00	2.2198	0.950	2.1091	8.9
3	13:39	7.00	0.6	0.900	0.6	0.360	2.2119	1.00	2.2119	0.900	1.9906	8.4
4	<i>13:40</i>	<i>8.00</i>	<i>0.6</i>	<i>0.950</i>	<i>0.6</i>	<i>0.380</i>	<i>2.7493</i>	<i>1.00</i>	<i>2.7493</i>	<i>0.950</i>	<i>2.6122</i>	<i>11.1</i>
5	13:42	9.00	0.6	1.000	0.6	0.400	2.5692	1.00	2.5692	1.000	2.5692	10.9
6	13:43	10.00	0.6	1.000	0.6	0.400	2.3583	1.00	2.3583	1.000	2.3583	10.0
7	13:44	11.00	0.6	1.000	0.6	0.400	3.2178	1.00	3.2178	1.000	3.2178	13.6
8	13:45	12.00	0.6	0.800	0.6	0.320	3.0148	1.00	3.0148	0.800	2.4114	10.2
9	13:46	13.00	0.6	0.700	0.6	0.280	2.5617	1.00	2.5617	0.700	1.7935	7.6
10	13:47	14.00	0.6	0.650	0.6	0.260	2.2264	1.00	2.2264	0.650	1.4470	6.1
11	13:48	15.00	0.6	0.550	0.6	0.220	1.1703	1.00	1.1703	0.550	0.6435	2.7
12	<i>13:49</i>	<i>16.00</i>	<i>0.6</i>	<i>0.800</i>	<i>0.6</i>	<i>0.320</i>	<i>0.0541</i>	<i>1.00</i>	<i>0.0541</i>	<i>0.800</i>	<i>0.0433</i>	<i>0.2</i>
13	<i>13:53</i>	<i>17.00</i>	<i>0.6</i>	<i>0.950</i>	<i>0.6</i>	<i>0.380</i>	<i>-0.0302</i>	<i>1.00</i>	<i>-0.0302</i>	<i>0.950</i>	<i>-0.0287</i>	<i>-0.1</i>
14	13:54	18.00	0.6	0.800	0.6	0.320	0.2041	1.00	0.2041	0.800	0.1632	0.7
15	13:55	19.00	0.6	0.750	0.6	0.300	0.5630	1.00	0.5630	0.750	0.4222	1.8
16	13:56	20.00	0.6	0.700	0.6	0.280	0.2467	1.00	0.2467	0.700	0.1727	0.7
17	13:57	21.00	0.6	0.650	0.6	0.260	0.1847	1.00	0.1847	0.650	0.1201	0.5
18	<i>13:59</i>	<i>22.00</i>	<i>0.6</i>	<i>0.450</i>	<i>0.6</i>	<i>0.180</i>	<i>0.2080</i>	<i>1.00</i>	<i>0.2080</i>	<i>0.450</i>	<i>0.0936</i>	<i>0.4</i>
19	13:59	23.00	None	0.300	0.0	0.0	0.0000	1.00	0.2080	0.150	0.0312	0.1

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary




Date Generated: Wed Jul 15 2015

File Information

File Name 150702AS.SPL.WAD
 Start Date and Time 2015/07/02 13:37:33

Site Details

Site Name ALABAMA SPILL
 Operator(s) MKH



Discharge Measurement Summary

Date Generated: Wed Jul 15 2015

File Information

File Name 150702AS.SPL.WAD
Start Date and Time 2015/07/02 13:37:33

Site Details

Site Name ALABAMA SPILL
Operator(s) MKH

Quality Control

St	Loc	%Dep	Message
4	8.00	0.6	High number of spikes: 7
12	16.00	0.6	High angle: 42
		0.6	Boundary QC is Good; possible boundary interference
13	17.00	0.6	High angle: 152
18	22.00	0.6	SNR (40.4) is different from typical SNR (50.7)

Discharge Measurement Summary

Date Generated: Wed Jul 15 2015

File Information

File Name 150703LS.SPL.WAD
Start Date and Time 2015/07/03 09:34:13

Site Details

Site Name
Operator(s) MKH

System Information

Sensor Type FlowTracker
Serial # P2352
CPU Firmware Version 3.7
Software Ver 2.30
Mounting Correction 0.0%

Units (English Units)

Distance ft
Velocity ft/s
Area ft²
Discharge cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.4%	2.4%
Velocity	0.5%	2.3%
Width	0.1%	0.1%
Method	1.8%	-
# Stations	2.4%	-
Overall	3.2%	3.5%

Summary

Averaging Int. 40 # Stations 21
Start Edge LEW Total Width 20.000
Mean SNR 55.5 dB Total Area 9.950
Mean Temp 78.17 °F Mean Depth 0.498
Disch. Equation Mid-Section Mean Velocity 2.2184
Total Discharge 22.0736

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	09:34	4.00	None	0.900	0.0	0.0	0.0000	1.00	1.6007	0.450	0.7203	3.3
1	09:34	5.00	0.6	0.800	0.6	0.320	1.6007	1.00	1.6007	0.800	1.2804	5.8
2	09:35	6.00	0.6	0.600	0.6	0.240	1.6611	1.00	1.6611	0.600	0.9968	4.5
3	09:38	7.00	0.6	0.450	0.6	0.180	1.9058	1.00	1.9058	0.450	0.8579	3.9
4	09:39	8.00	0.6	0.400	0.6	0.160	2.2687	1.00	2.2687	0.400	0.9073	4.1
5	09:40	9.00	0.6	0.400	0.6	0.160	2.8825	1.00	2.8825	0.400	1.1528	5.2
6	09:41	10.00	0.6	0.450	0.6	0.180	3.7740	1.00	3.7740	0.450	1.6988	7.7
7	09:42	11.00	0.6	0.450	0.6	0.180	3.9081	1.00	3.9081	0.450	1.7592	8.0
8	09:43	12.00	0.6	0.400	0.6	0.160	3.6772	1.00	3.6772	0.400	1.4706	6.7
9	09:44	13.00	0.6	0.400	0.6	0.160	4.1388	1.00	4.1388	0.400	1.6552	7.5
10	09:45	14.00	0.6	0.450	0.6	0.180	4.1306	1.00	4.1306	0.450	1.8593	8.4
11	09:47	15.00	0.6	0.450	0.6	0.180	3.6440	1.00	3.6440	0.450	1.6403	7.4
12	09:48	16.00	0.6	0.450	0.6	0.180	3.6030	1.00	3.6030	0.450	1.6218	7.3
13	09:49	17.00	0.6	0.400	0.6	0.160	2.8547	1.00	2.8547	0.400	1.1417	5.2
14	09:50	18.00	0.6	0.450	0.6	0.180	2.9941	1.00	2.9941	0.450	1.3477	6.1
15	09:51	19.00	0.6	0.400	0.6	0.160	2.1129	1.00	2.1129	0.400	0.8450	3.8
<i>16</i>	<i>09:53</i>	<i>20.00</i>	<i>0.6</i>	<i>0.450</i>	<i>0.6</i>	<i>0.180</i>	<i>1.0066</i>	<i>1.00</i>	<i>1.0066</i>	<i>0.450</i>	<i>0.4531</i>	<i>2.1</i>
17	09:55	21.00	0.6	0.650	0.6	0.260	0.3419	1.00	0.3419	0.650	0.2222	1.0
18	09:56	22.00	0.6	0.750	0.6	0.300	0.4833	1.00	0.4833	0.750	0.3625	1.6
<i>19</i>	<i>09:57</i>	<i>23.00</i>	<i>0.6</i>	<i>0.550</i>	<i>0.6</i>	<i>0.220</i>	<i>0.1155</i>	<i>1.00</i>	<i>0.1155</i>	<i>0.550</i>	<i>0.0635</i>	<i>0.3</i>
20	09:57	24.00	None	0.300	0.0	0.0	0.0000	1.00	0.1155	0.150	0.0173	0.1

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary




Date Generated: Wed Jul 15 2015

File Information

File Name 150703LS.SPL.WAD
 Start Date and Time 2015/07/03 09:34:13

Site Details

Site Name
 Operator(s) MKH



Discharge Measurement Summary

Date Generated: Wed Jul 15 2015

File Information

File Name 150703LS.SPL.WAD
Start Date and Time 2015/07/03 09:34:13

Site Details

Site Name
Operator(s) MKH

Quality Control

St	Loc	%Dep	Message
16	20.00	0.6	High number of spikes: 7
		0.6	SNR (42.8) is different from typical SNR (55.5)
		0.6	High SNR variation during measurement: 7.3,6.5
19	23.00	0.6	SNR (40.4) is different from typical SNR (55.5)

Discharge Measurement Summary

Date Generated: Wed Jul 15 2015

File Information


File Name 150703LS.SPL.WAD
Start Date and Time 2015/07/03 09:34:13

Site Details

Site Name
Operator(s) MKH

Automatic Quality Control Test (BeamCheck)

Fri Jul 3 09:32:56 PDT 2015



- ✔ Noise level check - Pass
- ✔ SNR check - Pass
- ✔ Peak location check - Pass
- ✔ Peak shape check - Pass

Discharge Measurement Summary

Date Generated: Wed Jul 15 2015

File Information

File Name 150705AS.SPL.WAD
Start Date and Time 2015/07/05 16:00:17

Site Details

Site Name ALABAMA SPILL
Operator(s) MKH

System Information

Sensor Type FlowTracker
Serial # P2352
CPU Firmware Version 3.7
Software Ver 2.30
Mounting Correction 0.0%

Units (English Units)

Distance ft
Velocity ft/s
Area ft²
Discharge cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.4%	2.2%
Velocity	0.5%	1.4%
Width	0.1%	0.1%
Method	1.9%	-
# Stations	2.4%	-
Overall	3.3%	2.8%

Summary

Averaging Int.	40	# Stations	21
Start Edge	LEW	Total Width	20.000
Mean SNR	53.6 dB	Total Area	7.675
Mean Temp	77.94 °F	Mean Depth	0.384
Disch. Equation	Mid-Section	Mean Velocity	2.4936
		Total Discharge	19.1384

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	16:00	4.00	None	0.400	0.0	0.0	0.0000	1.00	1.7730	0.200	0.3545	1.9
1	16:00	5.00	0.6	0.300	0.6	0.120	1.7730	1.00	1.7730	0.300	0.5317	2.8
2	16:01	6.00	0.6	0.300	0.6	0.120	1.9970	1.00	1.9970	0.300	0.5989	3.1
3	16:02	7.00	0.6	0.350	0.6	0.140	2.1122	1.00	2.1122	0.350	0.7394	3.9
4	16:03	8.00	0.6	0.400	0.6	0.160	2.3750	1.00	2.3750	0.400	0.9498	5.0
5	16:04	9.00	0.6	0.450	0.6	0.180	2.4777	1.00	2.4777	0.450	1.1153	5.8
6	16:05	10.00	0.6	0.500	0.6	0.200	3.1047	1.00	3.1047	0.500	1.5523	8.1
7	16:06	11.00	0.6	0.450	0.6	0.180	3.3107	1.00	3.3107	0.450	1.4902	7.8
8	16:07	12.00	0.6	0.450	0.6	0.180	3.1736	1.00	3.1736	0.450	1.4285	7.5
9	16:08	13.00	0.6	0.500	0.6	0.200	3.4498	1.00	3.4498	0.500	1.7249	9.0
10	16:09	14.00	0.6	0.500	0.6	0.200	3.1211	1.00	3.1211	0.500	1.5605	8.2
11	16:10	15.00	0.6	0.500	0.6	0.200	3.0768	1.00	3.0768	0.500	1.5384	8.0
12	16:11	16.00	0.6	0.500	0.6	0.200	3.0472	1.00	3.0472	0.500	1.5236	8.0
13	16:12	17.00	0.6	0.400	0.6	0.160	2.7201	1.00	2.7201	0.400	1.0879	5.7
14	16:13	18.00	0.6	0.450	0.6	0.180	2.6224	1.00	2.6224	0.450	1.1804	6.2
15	16:14	19.00	0.6	0.300	0.6	0.120	2.3018	1.00	2.3018	0.300	0.6902	3.6
16	16:15	20.00	0.6	0.300	0.6	0.120	1.7238	1.00	1.7238	0.300	0.5169	2.7
17	16:16	21.00	0.6	0.200	0.6	0.080	0.7976	1.00	0.7976	0.200	0.1596	0.8
<i>18</i>	<i>16:18</i>	<i>22.00</i>	<i>0.6</i>	<i>0.250</i>	<i>0.6</i>	<i>0.100</i>	<i>0.4580</i>	<i>1.00</i>	<i>0.4580</i>	<i>0.250</i>	<i>0.1145</i>	<i>0.6</i>
<i>19</i>	<i>16:19</i>	<i>23.00</i>	<i>0.6</i>	<i>0.250</i>	<i>0.6</i>	<i>0.100</i>	<i>0.7487</i>	<i>1.00</i>	<i>0.7487</i>	<i>0.250</i>	<i>0.1872</i>	<i>1.0</i>
20	16:19	24.00	None	0.250	0.0	0.0	0.0000	1.00	0.7487	0.125	0.0936	0.5

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary




Date Generated: Wed Jul 15 2015

File Information

File Name 150705AS.SPL.WAD
 Start Date and Time 2015/07/05 16:00:17

Site Details

Site Name ALABAMA SPILL
 Operator(s) MKH



Discharge Measurement Summary

Date Generated: Wed Jul 15 2015

File Information

File Name 150705AS.SPL.WAD
Start Date and Time 2015/07/05 16:00:17

Site Details

Site Name ALABAMA SPILL
Operator(s) MKH

Quality Control

St	Loc	%Dep	Message
18	22.00	0.6	High SNR variation during measurement: 5.2,5.6
19	23.00	0.6	SNR (38.9) is different from typical SNR (53.6)

Discharge Measurement Summary

Date Generated: Wed Jul 15 2015

File Information

File Name 150706LS.SPL.WAD
Start Date and Time 2015/07/06 07:50:34

Site Details

Site Name ALABAMA SPILL
Operator(s) MKH

System Information

Sensor Type FlowTracker
Serial # P2352
CPU Firmware Version 3.7
Software Ver 2.30
Mounting Correction 0.0%

Units (English Units)

Distance ft
Velocity ft/s
Area ft²
Discharge cfs

Discharge Uncertainty

Category	ISO	Stats
Accuracy	1.0%	1.0%
Depth	0.4%	1.9%
Velocity	0.6%	2.2%
Width	0.1%	0.1%
Method	1.9%	-
# Stations	2.3%	-
Overall	3.2%	3.0%

Summary

Averaging Int. 40 # Stations 22
Start Edge LEW Total Width 21.000
Mean SNR 51.0 dB Total Area 9.050
Mean Temp 66.69 °F Mean Depth 0.431
Disch. Equation Mid-Section Mean Velocity 2.2478
Total Discharge 20.3432

Measurement Results

St	Clock	Loc	Method	Depth	%Dep	MeasD	Vel	CorrFact	MeanV	Area	Flow	%Q
0	07:50	3.00	None	0.500	0.0	0.0	0.0000	1.00	0.6811	0.250	0.1703	0.8
1	07:50	4.00	0.6	0.600	0.6	0.240	0.6811	1.00	0.6811	0.600	0.4087	2.0
2	07:51	5.00	0.6	0.600	0.6	0.240	1.7946	1.00	1.7946	0.600	1.0769	5.3
3	07:52	6.00	0.6	0.500	0.6	0.200	2.0348	1.00	2.0348	0.500	1.0174	5.0
4	07:53	7.00	0.6	0.400	0.6	0.160	2.3219	1.00	2.3219	0.400	0.9286	4.6
5	07:54	8.00	0.6	0.500	0.6	0.200	2.5925	1.00	2.5925	0.500	1.2963	6.4
6	07:55	9.00	0.6	0.500	0.6	0.200	3.1499	1.00	3.1499	0.500	1.5750	7.7
7	07:56	10.00	0.6	0.450	0.6	0.180	3.3176	1.00	3.3176	0.450	1.4933	7.3
8	07:57	11.00	0.6	0.500	0.6	0.200	3.3045	1.00	3.3045	0.500	1.6522	8.1
9	07:59	12.00	0.6	0.600	0.6	0.240	3.1096	1.00	3.1096	0.600	1.8660	9.2
10	08:00	13.00	0.6	0.600	0.6	0.240	3.1138	1.00	3.1138	0.600	1.8685	9.2
11	08:01	14.00	0.6	0.550	0.6	0.220	3.2218	1.00	3.2218	0.550	1.7716	8.7
12	08:02	15.00	0.6	0.500	0.6	0.200	2.7867	1.00	2.7867	0.500	1.3934	6.8
13	08:03	16.00	0.6	0.450	0.6	0.180	2.7159	1.00	2.7159	0.450	1.2225	6.0
14	08:04	17.00	0.6	0.300	0.6	0.120	1.8425	1.00	1.8425	0.300	0.5525	2.7
15	08:05	18.00	0.6	0.300	0.6	0.120	2.0413	1.00	2.0413	0.300	0.6121	3.0
16	08:06	19.00	0.6	0.350	0.6	0.140	1.7454	1.00	1.7454	0.350	0.6110	3.0
17	08:07	20.00	0.6	0.300	0.6	0.120	1.4554	1.00	1.4554	0.300	0.4364	2.1
18	08:09	21.00	0.6	0.250	0.6	0.100	0.4593	1.00	0.4593	0.250	0.1148	0.6
19	08:11	22.00	0.6	0.200	0.6	0.080	0.4491	1.00	0.4491	0.200	0.0899	0.4
20	08:12	23.00	0.6	0.250	0.6	0.100	0.5308	1.00	0.5308	0.250	0.1327	0.7
21	08:12	24.00	None	0.200	0.0	0.0	0.0000	1.00	0.5308	0.100	0.0531	0.3

Rows in italics indicate a QC warning. See the Quality Control page of this report for more information.

Discharge Measurement Summary




Date Generated: Wed Jul 15 2015

File Information

File Name 150706LS.SPL.WAD
 Start Date and Time 2015/07/06 07:50:34

Site Details

Site Name ALABAMA SPILL
 Operator(s) MKH



Discharge Measurement Summary

Date Generated: Wed Jul 15 2015

File Information

File Name 150706LS.SPL.WAD
Start Date and Time 2015/07/06 07:50:34

Site Details

Site Name ALABAMA SPILL
Operator(s) MKH

Quality Control

No Quality Control warnings

Pumpback Station Discharge

DATE	FLOW (CFS)
7/1/2015	28
7/2/2015	30
7/3/2015	30
7/4/2015	31
7/5/2015	33
7/6/2015	37
7/7/2015	42
7/8/2015	45
7/9/2015	46
7/10/2015	43
7/11/2015	37
7/12/2015	40
7/13/2015	40
7/14/2015	40
7/15/2015	39
7/16/2015	38
7/17/2015	39
7/18/2015	39
7/19/2015	40
7/20/2015	42
7/21/2015	41
7/22/2015	45
7/23/2015	45
7/24/2015	45
7/25/2015	45
7/26/2015	45
7/27/2015	44
7/28/2015	37
7/29/2015	35
7/30/2015	35
7/31/2015	35

Langemann Gate to Delta

DATE	FLOW (CFS)
7/1/2015	4
7/2/2015	6
7/3/2015	10
7/4/2015	10
7/5/2015	10
7/6/2015	10
7/7/2015	5
7/8/2015	3
7/9/2015	3
7/10/2015	3
7/11/2015	3
7/12/2015	3
7/13/2015	3
7/14/2015	3
7/15/2015	3
7/16/2015	3
7/17/2015	3
7/18/2015	3
7/19/2015	3
7/20/2015	3
7/21/2015	3
7/22/2015	3
7/23/2015	4
7/24/2015	7
7/25/2015	8
7/26/2015	8
7/27/2015	8
7/28/2015	8
7/29/2015	8
7/30/2015	8
7/31/2015	8

Pumpback Station Weir to Delta

DATE	FLOW (CFS)
7/1/2015	0
7/2/2015	6
7/3/2015	0
7/4/2015	0
7/5/2015	0
7/6/2015	0
7/7/2015	0
7/8/2015	0
7/9/2015	0
7/10/2015	0
7/11/2015	0
7/12/2015	0.6
7/13/2015	0
7/14/2015	0
7/15/2015	0
7/16/2015	0
7/17/2015	0
7/18/2015	0
7/19/2015	0
7/20/2015	0
7/21/2015	1
7/22/2015	0
7/23/2015	1
7/24/2015	2
7/25/2015	2
7/26/2015	1
7/27/2015	0
7/28/2015	0
7/29/2015	0
7/30/2015	0
7/31/2015	0

Pumpback Station Discharge (0364)

7/1/15 0:00 == 32.5	7/1/15 4:35 == 32.9	7/1/15 9:10 == 33.9	7/1/15 13:45 == 14.8
7/1/15 0:05 == 32.5	7/1/15 4:40 == 33	7/1/15 9:15 == 34.1	7/1/15 13:50 == 14.5
7/1/15 0:10 == 32.4	7/1/15 4:45 == 32.9	7/1/15 9:20 == 34.2	7/1/15 13:55 == 15.4
7/1/15 0:15 == 32.5	7/1/15 4:50 == 32.7	7/1/15 9:25 == 34.2	7/1/15 14:00 == 31.6
7/1/15 0:20 == 32.5	7/1/15 4:55 == 32.3	7/1/15 9:30 == 34.2	7/1/15 14:05 == 31.7
7/1/15 0:25 == 32.5	7/1/15 5:00 == 42.3	7/1/15 9:35 == 34.2	7/1/15 14:10 == 32
7/1/15 0:30 == 32.5	7/1/15 5:05 == 46.1	7/1/15 9:40 == 34	7/1/15 14:15 == 31.6
7/1/15 0:35 == 32.5	7/1/15 5:10 == 46.4	7/1/15 9:45 == 33.9	7/1/15 14:20 == 31.7
7/1/15 0:40 == 32.6	7/1/15 5:15 == 46.2	7/1/15 9:50 == 33.9	7/1/15 14:25 == 31.8
7/1/15 0:45 == 32.6	7/1/15 5:20 == 46.1	7/1/15 9:55 == 33.7	7/1/15 14:30 == 31.8
7/1/15 0:50 == 32.6	7/1/15 5:25 == 46.2	7/1/15 10:00 == 33.4	7/1/15 14:35 == 31.8
7/1/15 0:55 == 32.7	7/1/15 5:30 == 46.4	7/1/15 10:05 == 33.4	7/1/15 14:40 == 31.7
7/1/15 1:00 == 32.6	7/1/15 5:35 == 46.3	7/1/15 10:10 == 33.4	7/1/15 14:45 == 31.9
7/1/15 1:05 == 32.6	7/1/15 5:40 == 44.8	7/1/15 10:15 == 33.1	7/1/15 14:50 == 31.9
7/1/15 1:10 == 32.7	7/1/15 5:45 == 32.1	7/1/15 10:20 == 33.1	7/1/15 14:55 == 31.8
7/1/15 1:15 == 32.6	7/1/15 5:50 == 31.5	7/1/15 10:25 == 31.2	7/1/15 15:00 == 32.2
7/1/15 1:20 == 32.7	7/1/15 5:55 == 31.6	7/1/15 10:30 == 15.1	7/1/15 15:05 == 31.9
7/1/15 1:25 == 32.7	7/1/15 6:00 == 32.1	7/1/15 10:35 == 15	7/1/15 15:10 == 31.9
7/1/15 1:30 == 32.6	7/1/15 6:05 == 31.5	7/1/15 10:40 == 15.1	7/1/15 15:15 == 32.1
7/1/15 1:35 == 32.5	7/1/15 6:10 == 31.9	7/1/15 10:45 == 15.5	7/1/15 15:20 == 32.1
7/1/15 1:40 == 32.6	7/1/15 6:15 == 32.2	7/1/15 10:50 == 15.4	7/1/15 15:25 == 32
7/1/15 1:45 == 32.7	7/1/15 6:20 == 32.2	7/1/15 10:55 == 16.3	7/1/15 15:30 == 31.7
7/1/15 1:50 == 32.7	7/1/15 6:25 == 32.1	7/1/15 11:00 == 33.4	7/1/15 15:35 == 31.8
7/1/15 1:55 == 32.7	7/1/15 6:30 == 32.3	7/1/15 11:05 == 33.8	7/1/15 15:40 == 32
7/1/15 2:00 == 32.6	7/1/15 6:35 == 32.3	7/1/15 11:10 == 33.8	7/1/15 15:45 == 32
7/1/15 2:05 == 32.8	7/1/15 6:40 == 32.3	7/1/15 11:15 == 33.4	7/1/15 15:50 == 32.1
7/1/15 2:10 == 32.7	7/1/15 6:45 == 32.4	7/1/15 11:20 == 33.3	7/1/15 15:55 == 32.1
7/1/15 2:15 == 32.6	7/1/15 6:50 == 32.4	7/1/15 11:25 == 33.2	7/1/15 16:00 == 31.7
7/1/15 2:20 == 32.7	7/1/15 6:55 == 32.4	7/1/15 11:30 == 32.9	7/1/15 16:05 == 31.6
7/1/15 2:25 == 32.7	7/1/15 7:00 == 32.4	7/1/15 11:35 == 32.7	7/1/15 16:10 == 31.8
7/1/15 2:30 == 32.6	7/1/15 7:05 == 32.4	7/1/15 11:40 == 30	7/1/15 16:15 == 32
7/1/15 2:35 == 32.7	7/1/15 7:10 == 32.4	7/1/15 11:45 == 14.7	7/1/15 16:20 == 32.2
7/1/15 2:40 == 32.8	7/1/15 7:15 == 32.5	7/1/15 11:50 == 14.4	7/1/15 16:25 == 32.2
7/1/15 2:45 == 32.6	7/1/15 7:20 == 32.4	7/1/15 11:55 == 14.4	7/1/15 16:30 == 32.1
7/1/15 2:50 == 32.6	7/1/15 7:25 == 32.4	7/1/15 12:00 == 15	7/1/15 16:35 == 31.9
7/1/15 2:55 == 32.8	7/1/15 7:30 == 32.5	7/1/15 12:05 == 14.8	7/1/15 16:40 == 32
7/1/15 3:00 == 32.7	7/1/15 7:35 == 32.5	7/1/15 12:10 == 15	7/1/15 16:45 == 32.3
7/1/15 3:05 == 32.7	7/1/15 7:40 == 32.7	7/1/15 12:15 == 15.3	7/1/15 16:50 == 32.1
7/1/15 3:10 == 32.9	7/1/15 7:45 == 32.1	7/1/15 12:20 == 15.3	7/1/15 16:55 == 32.2
7/1/15 3:15 == 32.9	7/1/15 7:50 == 32.5	7/1/15 12:25 == 16.3	7/1/15 17:00 == 32.1
7/1/15 3:20 == 32.7	7/1/15 7:55 == 32.3	7/1/15 12:30 == 33.5	7/1/15 17:05 == 32.2
7/1/15 3:25 == 32.8	7/1/15 8:00 == 32.3	7/1/15 12:35 == 33.3	7/1/15 17:10 == 32.1
7/1/15 3:30 == 32.8	7/1/15 8:05 == 32.3	7/1/15 12:40 == 33	7/1/15 17:15 == 32.2
7/1/15 3:35 == 32.8	7/1/15 8:10 == 32.5	7/1/15 12:45 == 33	7/1/15 17:20 == 32.2
7/1/15 3:40 == 32.9	7/1/15 8:15 == 32.2	7/1/15 12:50 == 32.4	7/1/15 17:25 == 32.1
7/1/15 3:45 == 32.9	7/1/15 8:20 == 32.2	7/1/15 12:55 == 32.5	7/1/15 17:30 == 32
7/1/15 3:50 == 32.8	7/1/15 8:25 == 32.8	7/1/15 13:00 == 32.7	7/1/15 17:35 == 32.1
7/1/15 3:55 == 32.9	7/1/15 8:30 == 33	7/1/15 13:05 == 33	7/1/15 17:40 == 32.1
7/1/15 4:00 == 32.8	7/1/15 8:35 == 33.3	7/1/15 13:10 == 32.7	7/1/15 17:45 == 32.1
7/1/15 4:05 == 32.8	7/1/15 8:40 == 33.5	7/1/15 13:15 == 32.8	7/1/15 17:50 == 32.2
7/1/15 4:10 == 32.8	7/1/15 8:45 == 33.5	7/1/15 13:20 == 32.5	7/1/15 17:55 == 32.1
7/1/15 4:15 == 32.8	7/1/15 8:50 == 32.9	7/1/15 13:25 == 30.6	7/1/15 18:00 == 32.1
7/1/15 4:20 == 32.7	7/1/15 8:55 == 33	7/1/15 13:30 == 14.5	7/1/15 18:05 == 32.1
7/1/15 4:25 == 32.8	7/1/15 9:00 == 33.3	7/1/15 13:35 == 14.4	7/1/15 18:10 == 32.1
7/1/15 4:30 == 32.9	7/1/15 9:05 == 34	7/1/15 13:40 == 14.5	7/1/15 18:15 == 32.1

Pumpback Station Discharge (0364)

7/1/15 18:20 == 32.2	7/1/15 22:55 == 0	7/2/15 3:30 == #	7/2/15 8:05 == 47.4
7/1/15 18:25 == 32.3	7/1/15 23:00 == #	7/2/15 3:35 == #	7/2/15 8:10 == 47.3
7/1/15 18:30 == 32.3	7/1/15 23:05 == 0	7/2/15 3:40 == 0	7/2/15 8:15 == 47.2
7/1/15 18:35 == 32.1	7/1/15 23:10 == 0	7/2/15 3:45 == 0	7/2/15 8:20 == 47.2
7/1/15 18:40 == 32.2	7/1/15 23:15 == 0	7/2/15 3:50 == 0	7/2/15 8:25 == 47
7/1/15 18:45 == 32.2	7/1/15 23:20 == #	7/2/15 3:55 == #	7/2/15 8:30 == 47.2
7/1/15 18:50 == 32.2	7/1/15 23:25 == #	7/2/15 4:00 == #	7/2/15 8:35 == 47.2
7/1/15 18:55 == 32.2	7/1/15 23:30 == 0	7/2/15 4:05 == 0	7/2/15 8:40 == 47.1
7/1/15 19:00 == 32.2	7/1/15 23:35 == 0	7/2/15 4:10 == 0	7/2/15 8:45 == 47.2
7/1/15 19:05 == 32.2	7/1/15 23:40 == #	7/2/15 4:15 == 0	7/2/15 8:50 == 47.5
7/1/15 19:10 == 32	7/1/15 23:45 == 0	7/2/15 4:20 == 0	7/2/15 8:55 == 47.1
7/1/15 19:15 == 32.2	7/1/15 23:50 == 0	7/2/15 4:25 == 0	7/2/15 9:00 == 47.3
7/1/15 19:20 == 32	7/1/15 23:55 == #	7/2/15 4:30 == 0	7/2/15 9:05 == 47.2
7/1/15 19:25 == 32.1	7/2/15 0:00 == 0	7/2/15 4:35 == #	7/2/15 9:10 == 47.3
7/1/15 19:30 == 32	7/2/15 0:05 == #	7/2/15 4:40 == #	7/2/15 9:15 == 47.2
7/1/15 19:35 == 32	7/2/15 0:10 == 0	7/2/15 4:45 == #	7/2/15 9:20 == 47.4
7/1/15 19:40 == 32.1	7/2/15 0:15 == 0	7/2/15 4:50 == #	7/2/15 9:25 == 47.2
7/1/15 19:45 == 32	7/2/15 0:20 == #	7/2/15 4:55 == 0	7/2/15 9:30 == 47.4
7/1/15 19:50 == 32.2	7/2/15 0:25 == 0	7/2/15 5:00 == 0	7/2/15 9:35 == 47.4
7/1/15 19:55 == 32.2	7/2/15 0:30 == 0	7/2/15 5:05 == #	7/2/15 9:40 == 47.4
7/1/15 20:00 == 32.3	7/2/15 0:35 == 0	7/2/15 5:10 == 0	7/2/15 9:45 == 47.5
7/1/15 20:05 == 32.3	7/2/15 0:40 == #	7/2/15 5:15 == #	7/2/15 9:50 == 47.3
7/1/15 20:10 == 32.3	7/2/15 0:45 == #	7/2/15 5:20 == 0	7/2/15 9:55 == 47.4
7/1/15 20:15 == 32.3	7/2/15 0:50 == 0	7/2/15 5:25 == #	7/2/15 10:00 == 47.3
7/1/15 20:20 == 32.5	7/2/15 0:55 == 0	7/2/15 5:30 == 0	7/2/15 10:05 == 47.3
7/1/15 20:25 == 32.4	7/2/15 1:00 == #	7/2/15 5:35 == #	7/2/15 10:10 == 47.2
7/1/15 20:30 == 32.5	7/2/15 1:05 == #	7/2/15 5:40 == 0	7/2/15 10:15 == 47.4
7/1/15 20:35 == 32.4	7/2/15 1:10 == 0	7/2/15 5:45 == 5.6	7/2/15 10:20 == 47.2
7/1/15 20:40 == 32.4	7/2/15 1:15 == 0	7/2/15 5:50 == 32.7	7/2/15 10:25 == 47.2
7/1/15 20:45 == 32.7	7/2/15 1:20 == #	7/2/15 5:55 == 33.5	7/2/15 10:30 == 47.4
7/1/15 20:50 == 32.6	7/2/15 1:25 == #	7/2/15 6:00 == 33.2	7/2/15 10:35 == 47.4
7/1/15 20:55 == 32.7	7/2/15 1:30 == 0	7/2/15 6:05 == 34.8	7/2/15 10:40 == 47.2
7/1/15 21:00 == 32.7	7/2/15 1:35 == 0	7/2/15 6:10 == 46.7	7/2/15 10:45 == 47.7
7/1/15 21:05 == 32.7	7/2/15 1:40 == 0	7/2/15 6:15 == 46.6	7/2/15 10:50 == 47.1
7/1/15 21:10 == 32.6	7/2/15 1:45 == 0	7/2/15 6:20 == 47.1	7/2/15 10:55 == 47.2
7/1/15 21:15 == 32.6	7/2/15 1:50 == #	7/2/15 6:25 == 47.1	7/2/15 11:00 == 47.1
7/1/15 21:20 == 32.6	7/2/15 1:55 == #	7/2/15 6:30 == 46.7	7/2/15 11:05 == 47.3
7/1/15 21:25 == 32.6	7/2/15 2:00 == #	7/2/15 6:35 == 46.8	7/2/15 11:10 == 47.3
7/1/15 21:30 == 32.5	7/2/15 2:05 == #	7/2/15 6:40 == 47	7/2/15 11:15 == 47.3
7/1/15 21:35 == 32.6	7/2/15 2:10 == #	7/2/15 6:45 == 46.8	7/2/15 11:20 == 47.1
7/1/15 21:40 == 32.6	7/2/15 2:15 == #	7/2/15 6:50 == 47	7/2/15 11:25 == 47.3
7/1/15 21:45 == 32.5	7/2/15 2:20 == #	7/2/15 6:55 == 46.8	7/2/15 11:30 == 47.1
7/1/15 21:50 == 32.6	7/2/15 2:25 == 0	7/2/15 7:00 == 46.9	7/2/15 11:35 == 47.2
7/1/15 21:55 == 32.6	7/2/15 2:30 == 0	7/2/15 7:05 == 47	7/2/15 11:40 == 47.3
7/1/15 22:00 == 32.5	7/2/15 2:35 == #	7/2/15 7:10 == 46.9	7/2/15 11:45 == 47.4
7/1/15 22:05 == 32.6	7/2/15 2:40 == #	7/2/15 7:15 == 47	7/2/15 11:50 == 47.3
7/1/15 22:10 == 31.8	7/2/15 2:45 == 0	7/2/15 7:20 == 47	7/2/15 11:55 == 47.1
7/1/15 22:15 == 25.2	7/2/15 2:50 == #	7/2/15 7:25 == 46.9	7/2/15 12:00 == 47.3
7/1/15 22:20 == 0	7/2/15 2:55 == 0	7/2/15 7:30 == 46.9	7/2/15 12:05 == 47.2
7/1/15 22:25 == 0	7/2/15 3:00 == 0	7/2/15 7:35 == 46.8	7/2/15 12:10 == 47.3
7/1/15 22:30 == #	7/2/15 3:05 == 0	7/2/15 7:40 == 46.9	7/2/15 12:15 == 47.3
7/1/15 22:35 == 0	7/2/15 3:10 == 0	7/2/15 7:45 == 46.9	7/2/15 12:20 == 47.2
7/1/15 22:40 == 0	7/2/15 3:15 == 0	7/2/15 7:50 == 46.6	7/2/15 12:25 == 47.1
7/1/15 22:45 == 0	7/2/15 3:20 == 0	7/2/15 7:55 == 46.7	7/2/15 12:30 == 47.3
7/1/15 22:50 == 0	7/2/15 3:25 == 0	7/2/15 8:00 == 46.7	7/2/15 12:35 == 47.3

Pumpback Station Discharge (0364)

7/2/15 12:40 == 47.1	7/2/15 17:15 == 31.9	7/2/15 21:50 == 31.4	7/3/15 2:25 == 30.8
7/2/15 12:45 == 47.4	7/2/15 17:20 == 31.9	7/2/15 21:55 == 31.3	7/3/15 2:30 == 30.8
7/2/15 12:50 == 47.1	7/2/15 17:25 == 31.8	7/2/15 22:00 == 31.3	7/3/15 2:35 == 30.8
7/2/15 12:55 == 47.4	7/2/15 17:30 == 31.8	7/2/15 22:05 == 31.3	7/3/15 2:40 == 30.8
7/2/15 13:00 == 47.2	7/2/15 17:35 == 31.8	7/2/15 22:10 == 31.3	7/3/15 2:45 == 30.7
7/2/15 13:05 == 47.2	7/2/15 17:40 == 31.9	7/2/15 22:15 == 31.2	7/3/15 2:50 == 30.7
7/2/15 13:10 == 47.1	7/2/15 17:45 == 31.8	7/2/15 22:20 == 31.4	7/3/15 2:55 == 30.8
7/2/15 13:15 == 47.2	7/2/15 17:50 == 31.9	7/2/15 22:25 == 31.3	7/3/15 3:00 == 30.6
7/2/15 13:20 == 47.1	7/2/15 17:55 == 31.7	7/2/15 22:30 == 31.3	7/3/15 3:05 == 30.6
7/2/15 13:25 == 47.2	7/2/15 18:00 == 31.7	7/2/15 22:35 == 31.3	7/3/15 3:10 == 30.7
7/2/15 13:30 == 47.2	7/2/15 18:05 == 31.7	7/2/15 22:40 == 31.3	7/3/15 3:15 == 30.6
7/2/15 13:35 == 47.3	7/2/15 18:10 == 31.8	7/2/15 22:45 == 31.3	7/3/15 3:20 == 30.7
7/2/15 13:40 == 47.3	7/2/15 18:15 == 31.7	7/2/15 22:50 == 31.2	7/3/15 3:25 == 30.7
7/2/15 13:45 == 47.4	7/2/15 18:20 == 31.9	7/2/15 22:55 == 31.3	7/3/15 3:30 == 30.7
7/2/15 13:50 == 47.2	7/2/15 18:25 == 31.7	7/2/15 23:00 == 31	7/3/15 3:35 == 30.6
7/2/15 13:55 == 47.1	7/2/15 18:30 == 31.8	7/2/15 23:05 == 31	7/3/15 3:40 == 30.6
7/2/15 14:00 == 47.3	7/2/15 18:35 == 31.9	7/2/15 23:10 == 31.1	7/3/15 3:45 == 30.6
7/2/15 14:05 == 47.2	7/2/15 18:40 == 32	7/2/15 23:15 == 31.1	7/3/15 3:50 == 30.6
7/2/15 14:10 == 47	7/2/15 18:45 == 31.8	7/2/15 23:20 == 31.2	7/3/15 3:55 == 30.6
7/2/15 14:15 == 47.1	7/2/15 18:50 == 31.8	7/2/15 23:25 == 31.1	7/3/15 4:00 == 30.6
7/2/15 14:20 == 47.3	7/2/15 18:55 == 31.9	7/2/15 23:30 == 31.1	7/3/15 4:05 == 30.6
7/2/15 14:25 == 47.1	7/2/15 19:00 == 31.6	7/2/15 23:35 == 31.1	7/3/15 4:10 == 30.6
7/2/15 14:30 == 46.9	7/2/15 19:05 == 31.8	7/2/15 23:40 == 31.1	7/3/15 4:15 == 30.5
7/2/15 14:35 == 47	7/2/15 19:10 == 31.8	7/2/15 23:45 == 31.2	7/3/15 4:20 == 30.7
7/2/15 14:40 == 47	7/2/15 19:15 == 31.8	7/2/15 23:50 == 31.2	7/3/15 4:25 == 30.6
7/2/15 14:45 == 47.2	7/2/15 19:20 == 31.7	7/2/15 23:55 == 31.1	7/3/15 4:30 == 30.5
7/2/15 14:50 == 47.2	7/2/15 19:25 == 31.7	7/3/15 0:00 == 31	7/3/15 4:35 == 30.6
7/2/15 14:55 == 44.5	7/2/15 19:30 == 31.7	7/3/15 0:05 == 31.1	7/3/15 4:40 == 30.4
7/2/15 15:00 == 31.6	7/2/15 19:35 == 31.7	7/3/15 0:10 == 30.9	7/3/15 4:45 == 30.6
7/2/15 15:05 == 31.5	7/2/15 19:40 == 31.8	7/3/15 0:15 == 31	7/3/15 4:50 == 30.5
7/2/15 15:10 == 31.7	7/2/15 19:45 == 31.8	7/3/15 0:20 == 31.1	7/3/15 4:55 == 30.6
7/2/15 15:15 == 32.1	7/2/15 19:50 == 31.7	7/3/15 0:25 == 30.9	7/3/15 5:00 == 30.4
7/2/15 15:20 == 32	7/2/15 19:55 == 31.7	7/3/15 0:30 == 31	7/3/15 5:05 == 30.5
7/2/15 15:25 == 31.8	7/2/15 20:00 == 31.7	7/3/15 0:35 == 31	7/3/15 5:10 == 30.5
7/2/15 15:30 == 32.1	7/2/15 20:05 == 31.5	7/3/15 0:40 == 30.9	7/3/15 5:15 == 30.5
7/2/15 15:35 == 32.1	7/2/15 20:10 == 31.6	7/3/15 0:45 == 31	7/3/15 5:20 == 30.6
7/2/15 15:40 == 32	7/2/15 20:15 == 31.6	7/3/15 0:50 == 30.9	7/3/15 5:25 == 30.6
7/2/15 15:45 == 31.9	7/2/15 20:20 == 31.6	7/3/15 0:55 == 31	7/3/15 5:30 == 30.5
7/2/15 15:50 == 31.9	7/2/15 20:25 == 31.5	7/3/15 1:00 == 30.9	7/3/15 5:35 == 30.5
7/2/15 15:55 == 32	7/2/15 20:30 == 31.5	7/3/15 1:05 == 30.9	7/3/15 5:40 == 25.7
7/2/15 16:00 == 32.1	7/2/15 20:35 == 31.4	7/3/15 1:10 == 30.8	7/3/15 5:45 == 12.6
7/2/15 16:05 == 32	7/2/15 20:40 == 31.5	7/3/15 1:15 == 30.8	7/3/15 5:50 == 12.8
7/2/15 16:10 == 32	7/2/15 20:45 == 31.5	7/3/15 1:20 == 30.8	7/3/15 5:55 == 12.9
7/2/15 16:15 == 31.9	7/2/15 20:50 == 31.4	7/3/15 1:25 == 30.9	7/3/15 6:00 == 13.5
7/2/15 16:20 == 32	7/2/15 20:55 == 31.4	7/3/15 1:30 == 30.9	7/3/15 6:05 == 13.5
7/2/15 16:25 == 31.9	7/2/15 21:00 == 31.2	7/3/15 1:35 == 30.8	7/3/15 6:10 == 17.5
7/2/15 16:30 == 32.2	7/2/15 21:05 == 31.4	7/3/15 1:40 == 30.9	7/3/15 6:15 == 31.9
7/2/15 16:35 == 32.1	7/2/15 21:10 == 31.5	7/3/15 1:45 == 30.8	7/3/15 6:20 == 31.9
7/2/15 16:40 == 32.1	7/2/15 21:15 == 31.3	7/3/15 1:50 == 30.9	7/3/15 6:25 == 31.8
7/2/15 16:45 == 32.1	7/2/15 21:20 == 31.3	7/3/15 1:55 == 30.8	7/3/15 6:30 == 31.6
7/2/15 16:50 == 32.1	7/2/15 21:25 == 31.3	7/3/15 2:00 == 30.8	7/3/15 6:35 == 31.6
7/2/15 16:55 == 32.1	7/2/15 21:30 == 31.3	7/3/15 2:05 == 30.8	7/3/15 6:40 == 31.3
7/2/15 17:00 == 31.8	7/2/15 21:35 == 31.4	7/3/15 2:10 == 30.8	7/3/15 6:45 == 31.1
7/2/15 17:05 == 31.9	7/2/15 21:40 == 31.4	7/3/15 2:15 == 30.8	7/3/15 6:50 == 31.1
7/2/15 17:10 == 31.9	7/2/15 21:45 == 31.4	7/3/15 2:20 == 30.8	7/3/15 6:55 == 31.1

Pumpback Station Discharge (0364)

7/3/15 7:00 == 30.8	7/3/15 11:35 == 31	7/3/15 16:10 == 31.2	7/3/15 20:45 == 31
7/3/15 7:05 == 30.9	7/3/15 11:40 == 31.1	7/3/15 16:15 == 31.2	7/3/15 20:50 == 31
7/3/15 7:10 == 30.8	7/3/15 11:45 == 31.2	7/3/15 16:20 == 31.3	7/3/15 20:55 == 31
7/3/15 7:15 == 30.7	7/3/15 11:50 == 31.2	7/3/15 16:25 == 31.3	7/3/15 21:00 == 31
7/3/15 7:20 == 30.6	7/3/15 11:55 == 31.2	7/3/15 16:30 == 31.2	7/3/15 21:05 == 30.9
7/3/15 7:25 == 30.6	7/3/15 12:00 == 31	7/3/15 16:35 == 31.2	7/3/15 21:10 == 31.2
7/3/15 7:30 == 30.6	7/3/15 12:05 == 31.3	7/3/15 16:40 == 31.1	7/3/15 21:15 == 31.2
7/3/15 7:35 == 30.5	7/3/15 12:10 == 31.3	7/3/15 16:45 == 31	7/3/15 21:20 == 31.2
7/3/15 7:40 == 25.7	7/3/15 12:15 == 31.3	7/3/15 16:50 == 31	7/3/15 21:25 == 31
7/3/15 7:45 == 12.7	7/3/15 12:20 == 31.4	7/3/15 16:55 == 31.2	7/3/15 21:30 == 30.8
7/3/15 7:50 == 12.9	7/3/15 12:25 == 31.4	7/3/15 17:00 == 31.3	7/3/15 21:35 == 30.7
7/3/15 7:55 == 13.1	7/3/15 12:30 == 31.7	7/3/15 17:05 == 31.2	7/3/15 21:40 == 30.8
7/3/15 8:00 == 13.5	7/3/15 12:35 == 31.6	7/3/15 17:10 == 31.3	7/3/15 21:45 == 30.9
7/3/15 8:05 == 13.5	7/3/15 12:40 == 31.7	7/3/15 17:15 == 31.1	7/3/15 21:50 == 30.9
7/3/15 8:10 == 17.8	7/3/15 12:45 == 31.5	7/3/15 17:20 == 31.2	7/3/15 21:55 == 30.9
7/3/15 8:15 == 31.8	7/3/15 12:50 == 31.7	7/3/15 17:25 == 31.2	7/3/15 22:00 == 30.8
7/3/15 8:20 == 32	7/3/15 12:55 == 31.6	7/3/15 17:30 == 31.2	7/3/15 22:05 == 30.9
7/3/15 8:25 == 31.3	7/3/15 13:00 == 31.6	7/3/15 17:35 == 31.2	7/3/15 22:10 == 30.7
7/3/15 8:30 == 31.5	7/3/15 13:05 == 31.6	7/3/15 17:40 == 31.2	7/3/15 22:15 == 30.9
7/3/15 8:35 == 31.4	7/3/15 13:10 == 31.5	7/3/15 17:45 == 31.3	7/3/15 22:20 == 31.1
7/3/15 8:40 == 31.4	7/3/15 13:15 == 31.6	7/3/15 17:50 == 31.3	7/3/15 22:25 == 31.1
7/3/15 8:45 == 31.3	7/3/15 13:20 == 31.8	7/3/15 17:55 == 31.3	7/3/15 22:30 == 31.1
7/3/15 8:50 == 31.4	7/3/15 13:25 == 31.8	7/3/15 18:00 == 31.2	7/3/15 22:35 == 31
7/3/15 8:55 == 31.4	7/3/15 13:30 == 31.8	7/3/15 18:05 == 31.3	7/3/15 22:40 == 31.1
7/3/15 9:00 == 31.3	7/3/15 13:35 == 31.7	7/3/15 18:10 == 31.2	7/3/15 22:45 == 30.8
7/3/15 9:05 == 31.5	7/3/15 13:40 == 31.9	7/3/15 18:15 == 31.2	7/3/15 22:50 == 30.9
7/3/15 9:10 == 31.3	7/3/15 13:45 == 31.9	7/3/15 18:20 == 31.2	7/3/15 22:55 == 31
7/3/15 9:15 == 31	7/3/15 13:50 == 31.8	7/3/15 18:25 == 31.2	7/3/15 23:00 == 31
7/3/15 9:20 == 31.3	7/3/15 13:55 == 31.9	7/3/15 18:30 == 31.2	7/3/15 23:05 == 30.8
7/3/15 9:25 == 31	7/3/15 14:00 == 31.8	7/3/15 18:35 == 31.1	7/3/15 23:10 == 30.9
7/3/15 9:30 == 31.1	7/3/15 14:05 == 31.8	7/3/15 18:40 == 31.2	7/3/15 23:15 == 30.8
7/3/15 9:35 == 30.9	7/3/15 14:10 == 31.8	7/3/15 18:45 == 31.2	7/3/15 23:20 == 30.9
7/3/15 9:40 == 30.9	7/3/15 14:15 == 31.7	7/3/15 18:50 == 31.2	7/3/15 23:25 == 31
7/3/15 9:45 == 30.7	7/3/15 14:20 == 31.8	7/3/15 18:55 == 31.1	7/3/15 23:30 == 30.9
7/3/15 9:50 == #	7/3/15 14:25 == 31.7	7/3/15 19:00 == 31.1	7/3/15 23:35 == 30.8
7/3/15 9:55 == 30.9	7/3/15 14:30 == 31.8	7/3/15 19:05 == 31	7/3/15 23:40 == 30.9
7/3/15 10:00 == 30.6	7/3/15 14:35 == 31.7	7/3/15 19:10 == 31.1	7/3/15 23:45 == 30.9
7/3/15 10:05 == 30.8	7/3/15 14:40 == 31.5	7/3/15 19:15 == 31	7/3/15 23:50 == 30.8
7/3/15 10:10 == 30.7	7/3/15 14:45 == 31.6	7/3/15 19:20 == 31.1	7/3/15 23:55 == 30.8
7/3/15 10:15 == 30.7	7/3/15 14:50 == 31.6	7/3/15 19:25 == 31.1	7/4/15 0:00 == 30.7
7/3/15 10:20 == 30.6	7/3/15 14:55 == 31.5	7/3/15 19:30 == 31.3	7/4/15 0:05 == 30.8
7/3/15 10:25 == 30.7	7/3/15 15:00 == 31.2	7/3/15 19:35 == 31	7/4/15 0:10 == 30.5
7/3/15 10:30 == 30.9	7/3/15 15:05 == 31.3	7/3/15 19:40 == 31	7/4/15 0:15 == 30.5
7/3/15 10:35 == 30.6	7/3/15 15:10 == 31.5	7/3/15 19:45 == 30.9	7/4/15 0:20 == 30.6
7/3/15 10:40 == 30.7	7/3/15 15:15 == 31.2	7/3/15 19:50 == 31	7/4/15 0:25 == 30.6
7/3/15 10:45 == 30.8	7/3/15 15:20 == 31.4	7/3/15 19:55 == 31	7/4/15 0:30 == 30.7
7/3/15 10:50 == 30.7	7/3/15 15:25 == 31.2	7/3/15 20:00 == 31	7/4/15 0:35 == 30.7
7/3/15 10:55 == 30.8	7/3/15 15:30 == 31.4	7/3/15 20:05 == 31.1	7/4/15 0:40 == 30.8
7/3/15 11:00 == 30.9	7/3/15 15:35 == 31.2	7/3/15 20:10 == 30.9	7/4/15 0:45 == 30.7
7/3/15 11:05 == 31	7/3/15 15:40 == 31.3	7/3/15 20:15 == 31.1	7/4/15 0:50 == 30.7
7/3/15 11:10 == 31.1	7/3/15 15:45 == 31.2	7/3/15 20:20 == 31.1	7/4/15 0:55 == 30.7
7/3/15 11:15 == 30.8	7/3/15 15:50 == 31.2	7/3/15 20:25 == 31.1	7/4/15 1:00 == 30.8
7/3/15 11:20 == 30.9	7/3/15 15:55 == 31.2	7/3/15 20:30 == 30.9	7/4/15 1:05 == 30.8
7/3/15 11:25 == 30.9	7/3/15 16:00 == 31.2	7/3/15 20:35 == 31	7/4/15 1:10 == 30.6
7/3/15 11:30 == 31.2	7/3/15 16:05 == 31.2	7/3/15 20:40 == 31	7/4/15 1:15 == 30.5

Pumpback Station Discharge (0364)

7/4/15 1:20 == 30.5	7/4/15 5:55 == 30.7	7/4/15 10:30 == 31.1	7/4/15 15:05 == 32.4
7/4/15 1:25 == 30.5	7/4/15 6:00 == 30.9	7/4/15 10:35 == 31.2	7/4/15 15:10 == 31.9
7/4/15 1:30 == 30.5	7/4/15 6:05 == 30.8	7/4/15 10:40 == 31	7/4/15 15:15 == 32
7/4/15 1:35 == 30.6	7/4/15 6:10 == 30.7	7/4/15 10:45 == 31.1	7/4/15 15:20 == 31.9
7/4/15 1:40 == 30.5	7/4/15 6:15 == 30.8	7/4/15 10:50 == 31.1	7/4/15 15:25 == 32.1
7/4/15 1:45 == 30.6	7/4/15 6:20 == 30.7	7/4/15 10:55 == 31.1	7/4/15 15:30 == 32.1
7/4/15 1:50 == 30.5	7/4/15 6:25 == 30.7	7/4/15 11:00 == 31.2	7/4/15 15:35 == 32.1
7/4/15 1:55 == 30.7	7/4/15 6:30 == 30.7	7/4/15 11:05 == 31.2	7/4/15 15:40 == 32.2
7/4/15 2:00 == 30.5	7/4/15 6:35 == 30.7	7/4/15 11:10 == 30.3	7/4/15 15:45 == 32.2
7/4/15 2:05 == 30.6	7/4/15 6:40 == 30.7	7/4/15 11:15 == 30.8	7/4/15 15:50 == 32.2
7/4/15 2:10 == 30.5	7/4/15 6:45 == 30.7	7/4/15 11:20 == 30.7	7/4/15 15:55 == 31.9
7/4/15 2:15 == 30.5	7/4/15 6:50 == 30.8	7/4/15 11:25 == 30.7	7/4/15 16:00 == 31.8
7/4/15 2:20 == 30.6	7/4/15 6:55 == 30.8	7/4/15 11:30 == 30.9	7/4/15 16:05 == 32
7/4/15 2:25 == 30.5	7/4/15 7:00 == 30.9	7/4/15 11:35 == 30.8	7/4/15 16:10 == 32.1
7/4/15 2:30 == 30.6	7/4/15 7:05 == 30.8	7/4/15 11:40 == 30.8	7/4/15 16:15 == 32.2
7/4/15 2:35 == 30.8	7/4/15 7:10 == 24	7/4/15 11:45 == 30.8	7/4/15 16:20 == 32.1
7/4/15 2:40 == 30.4	7/4/15 7:15 == 13.1	7/4/15 11:50 == 30.8	7/4/15 16:25 == 32.1
7/4/15 2:45 == 30.5	7/4/15 7:20 == 13.1	7/4/15 11:55 == 24	7/4/15 16:30 == 32.2
7/4/15 2:50 == 30.6	7/4/15 7:25 == 13.5	7/4/15 12:00 == 12.9	7/4/15 16:35 == 32.2
7/4/15 2:55 == 30.6	7/4/15 7:30 == 14.5	7/4/15 12:05 == 13.1	7/4/15 16:40 == 32.3
7/4/15 3:00 == 30.7	7/4/15 7:35 == 14.4	7/4/15 12:10 == 13.4	7/4/15 16:45 == 32
7/4/15 3:05 == 30.6	7/4/15 7:40 == 20.2	7/4/15 12:15 == 14	7/4/15 16:50 == 32.1
7/4/15 3:10 == 30.6	7/4/15 7:45 == 32.4	7/4/15 12:20 == 14.1	7/4/15 16:55 == 32.1
7/4/15 3:15 == 30.6	7/4/15 7:50 == 32.4	7/4/15 12:25 == 20.4	7/4/15 17:00 == 32
7/4/15 3:20 == 30.5	7/4/15 7:55 == 32.2	7/4/15 12:30 == 32.1	7/4/15 17:05 == 32.2
7/4/15 3:25 == 30.5	7/4/15 8:00 == 32.2	7/4/15 12:35 == 32.3	7/4/15 17:10 == 31.9
7/4/15 3:30 == 30.5	7/4/15 8:05 == 32.3	7/4/15 12:40 == 32.1	7/4/15 17:15 == 32
7/4/15 3:35 == 30.6	7/4/15 8:10 == 32.3	7/4/15 12:45 == 31.9	7/4/15 17:20 == 31.9
7/4/15 3:40 == 30.5	7/4/15 8:15 == 32	7/4/15 12:50 == 31.9	7/4/15 17:25 == 32
7/4/15 3:45 == 30.6	7/4/15 8:20 == 32.2	7/4/15 12:55 == 32.2	7/4/15 17:30 == 31.9
7/4/15 3:50 == 30.6	7/4/15 8:25 == 32.1	7/4/15 13:00 == 32	7/4/15 17:35 == 31.9
7/4/15 3:55 == 30.7	7/4/15 8:30 == 32.1	7/4/15 13:05 == 31.9	7/4/15 17:40 == 31.9
7/4/15 4:00 == 30.5	7/4/15 8:35 == 32.1	7/4/15 13:10 == 32	7/4/15 17:45 == 31.9
7/4/15 4:05 == 30.6	7/4/15 8:40 == 32.2	7/4/15 13:15 == 32	7/4/15 17:50 == 31.9
7/4/15 4:10 == 30.4	7/4/15 8:45 == 32.1	7/4/15 13:20 == 32	7/4/15 17:55 == 31.9
7/4/15 4:15 == 30.5	7/4/15 8:50 == 32.1	7/4/15 13:25 == 31.9	7/4/15 18:00 == 32
7/4/15 4:20 == 30.5	7/4/15 8:55 == 32.1	7/4/15 13:30 == 32	7/4/15 18:05 == 32
7/4/15 4:25 == 30.5	7/4/15 9:00 == 32.3	7/4/15 13:35 == 31.8	7/4/15 18:10 == 32.2
7/4/15 4:30 == 30.6	7/4/15 9:05 == 32.3	7/4/15 13:40 == 32	7/4/15 18:15 == 32.1
7/4/15 4:35 == 30.4	7/4/15 9:10 == 32	7/4/15 13:45 == 32.1	7/4/15 18:20 == 32.1
7/4/15 4:40 == 30.6	7/4/15 9:15 == 31.7	7/4/15 13:50 == 32	7/4/15 18:25 == 32
7/4/15 4:45 == 30.4	7/4/15 9:20 == 31.4	7/4/15 13:55 == 32.2	7/4/15 18:30 == 32
7/4/15 4:50 == 30.5	7/4/15 9:25 == 31.5	7/4/15 14:00 == 32.1	7/4/15 18:35 == 31.9
7/4/15 4:55 == 30.5	7/4/15 9:30 == 31.6	7/4/15 14:05 == 32.2	7/4/15 18:40 == 31.9
7/4/15 5:00 == 30.4	7/4/15 9:35 == 31.6	7/4/15 14:10 == 31.8	7/4/15 18:45 == 31.9
7/4/15 5:05 == 30.3	7/4/15 9:40 == 31.4	7/4/15 14:15 == 31.6	7/4/15 18:50 == 31.9
7/4/15 5:10 == 30.4	7/4/15 9:45 == 31.3	7/4/15 14:20 == 31.8	7/4/15 18:55 == 31.9
7/4/15 5:15 == 30.5	7/4/15 9:50 == 31.4	7/4/15 14:25 == 31.8	7/4/15 19:00 == 32
7/4/15 5:20 == 30.5	7/4/15 9:55 == 31.4	7/4/15 14:30 == 32	7/4/15 19:05 == 32.1
7/4/15 5:25 == 30.4	7/4/15 10:00 == 30.8	7/4/15 14:35 == #	7/4/15 19:10 == 31.9
7/4/15 5:30 == 30.4	7/4/15 10:05 == 30.8	7/4/15 14:40 == 32.2	7/4/15 19:15 == 32.2
7/4/15 5:35 == 30.4	7/4/15 10:10 == 30.9	7/4/15 14:45 == 32.1	7/4/15 19:20 == 31.9
7/4/15 5:40 == 30.4	7/4/15 10:15 == 31.2	7/4/15 14:50 == 32.2	7/4/15 19:25 == 32.1
7/4/15 5:45 == 30.5	7/4/15 10:20 == 31.2	7/4/15 14:55 == 32.1	7/4/15 19:30 == 32
7/4/15 5:50 == 31	7/4/15 10:25 == 31.1	7/4/15 15:00 == 32	7/4/15 19:35 == 32.1

Pumpback Station Discharge (0364)

7/4/15 19:40 == 32.1	7/5/15 0:15 == 32.1	7/5/15 4:50 == 32.3	7/5/15 9:25 == 32.9
7/4/15 19:45 == 32.1	7/5/15 0:20 == 32.2	7/5/15 4:55 == 32.2	7/5/15 9:30 == 32.5
7/4/15 19:50 == 32.2	7/5/15 0:25 == 32.2	7/5/15 5:00 == 32.4	7/5/15 9:35 == 32.6
7/4/15 19:55 == 32.1	7/5/15 0:30 == 32.3	7/5/15 5:05 == 32.3	7/5/15 9:40 == 32.7
7/4/15 20:00 == #	7/5/15 0:35 == 32.2	7/5/15 5:10 == 32.5	7/5/15 9:45 == 32.6
7/4/15 20:05 == 32.2	7/5/15 0:40 == 32.3	7/5/15 5:15 == 32.4	7/5/15 9:50 == 32.7
7/4/15 20:10 == 32.1	7/5/15 0:45 == 32.3	7/5/15 5:20 == 32.4	7/5/15 9:55 == 32.7
7/4/15 20:15 == 32.2	7/5/15 0:50 == 32.3	7/5/15 5:25 == 32.3	7/5/15 10:00 == 32.6
7/4/15 20:20 == 32.3	7/5/15 0:55 == 32.2	7/5/15 5:30 == 32.3	7/5/15 10:05 == 32.7
7/4/15 20:25 == 32.2	7/5/15 1:00 == 32.2	7/5/15 5:35 == 32.4	7/5/15 10:10 == 32.6
7/4/15 20:30 == 32.2	7/5/15 1:05 == 32.1	7/5/15 5:40 == 32.4	7/5/15 10:15 == 32.6
7/4/15 20:35 == 32.1	7/5/15 1:10 == 32.2	7/5/15 5:45 == 32.5	7/5/15 10:20 == 32.6
7/4/15 20:40 == 32.1	7/5/15 1:15 == 32.2	7/5/15 5:50 == 32.4	7/5/15 10:25 == 32.7
7/4/15 20:45 == 32.2	7/5/15 1:20 == 32.2	7/5/15 5:55 == 32.6	7/5/15 10:30 == 32.7
7/4/15 20:50 == 32.1	7/5/15 1:25 == 32.1	7/5/15 6:00 == 32.3	7/5/15 10:35 == 32.6
7/4/15 20:55 == 32.2	7/5/15 1:30 == 32.2	7/5/15 6:05 == 32.5	7/5/15 10:40 == 32.6
7/4/15 21:00 == 32.1	7/5/15 1:35 == 32.2	7/5/15 6:10 == 32.4	7/5/15 10:45 == 32.6
7/4/15 21:05 == 32	7/5/15 1:40 == 32.2	7/5/15 6:15 == 32.4	7/5/15 10:50 == 32.8
7/4/15 21:10 == 32.1	7/5/15 1:45 == 32.3	7/5/15 6:20 == 32.4	7/5/15 10:55 == 32.7
7/4/15 21:15 == 32.2	7/5/15 1:50 == 32.2	7/5/15 6:25 == 32.3	7/5/15 11:00 == 32.7
7/4/15 21:20 == 32.3	7/5/15 1:55 == 32.4	7/5/15 6:30 == 32.6	7/5/15 11:05 == 32.8
7/4/15 21:25 == 32.2	7/5/15 2:00 == 32.2	7/5/15 6:35 == 32.5	7/5/15 11:10 == 32.8
7/4/15 21:30 == 32.1	7/5/15 2:05 == 32.3	7/5/15 6:40 == 32.5	7/5/15 11:15 == 32.9
7/4/15 21:35 == 32.1	7/5/15 2:10 == 32.3	7/5/15 6:45 == 32.3	7/5/15 11:20 == 33
7/4/15 21:40 == 32.2	7/5/15 2:15 == 32.2	7/5/15 6:50 == 32.3	7/5/15 11:25 == 32.7
7/4/15 21:45 == 32.2	7/5/15 2:20 == 32.1	7/5/15 6:55 == 32.3	7/5/15 11:30 == 34.4
7/4/15 21:50 == 32.1	7/5/15 2:25 == 32.1	7/5/15 7:00 == 32.1	7/5/15 11:35 == 46.6
7/4/15 21:55 == 32.2	7/5/15 2:30 == 32.2	7/5/15 7:05 == 32	7/5/15 11:40 == 46.3
7/4/15 22:00 == 32.1	7/5/15 2:35 == 32.2	7/5/15 7:10 == 32	7/5/15 11:45 == 46.5
7/4/15 22:05 == 32.3	7/5/15 2:40 == 32.5	7/5/15 7:15 == 31.9	7/5/15 11:50 == 46.3
7/4/15 22:10 == 32.1	7/5/15 2:45 == 32.2	7/5/15 7:20 == 32	7/5/15 11:55 == 46.4
7/4/15 22:15 == 32.2	7/5/15 2:50 == 32.4	7/5/15 7:25 == 31.9	7/5/15 12:00 == 46.4
7/4/15 22:20 == 32.1	7/5/15 2:55 == 32.2	7/5/15 7:30 == 31.8	7/5/15 12:05 == 46.3
7/4/15 22:25 == 32.3	7/5/15 3:00 == 32.3	7/5/15 7:35 == 31.7	7/5/15 12:10 == 46.7
7/4/15 22:30 == 32.2	7/5/15 3:05 == 32.3	7/5/15 7:40 == 31.8	7/5/15 12:15 == 46.4
7/4/15 22:35 == 32.3	7/5/15 3:10 == 32.3	7/5/15 7:45 == 31.6	7/5/15 12:20 == 46.5
7/4/15 22:40 == 32.3	7/5/15 3:15 == 32.4	7/5/15 7:50 == 31.8	7/5/15 12:25 == 46.4
7/4/15 22:45 == 32.3	7/5/15 3:20 == 32.4	7/5/15 7:55 == 31.7	7/5/15 12:30 == 39.8
7/4/15 22:50 == 32.2	7/5/15 3:25 == 32.2	7/5/15 8:00 == 31.6	7/5/15 12:35 == 31.8
7/4/15 22:55 == 32.3	7/5/15 3:30 == 32.2	7/5/15 8:05 == 31.7	7/5/15 12:40 == 31.8
7/4/15 23:00 == 32.3	7/5/15 3:35 == 32	7/5/15 8:10 == 31.8	7/5/15 12:45 == 32.3
7/4/15 23:05 == 32.2	7/5/15 3:40 == 32.1	7/5/15 8:15 == 31.8	7/5/15 12:50 == 32.4
7/4/15 23:10 == 32.3	7/5/15 3:45 == 32.3	7/5/15 8:20 == 31.9	7/5/15 12:55 == 32.4
7/4/15 23:15 == 32.3	7/5/15 3:50 == 32.3	7/5/15 8:25 == 32	7/5/15 13:00 == 32.6
7/4/15 23:20 == 32.2	7/5/15 3:55 == 32.3	7/5/15 8:30 == 32.1	7/5/15 13:05 == 32.5
7/4/15 23:25 == 32.1	7/5/15 4:00 == 32.3	7/5/15 8:35 == 32.3	7/5/15 13:10 == 32.2
7/4/15 23:30 == 32.2	7/5/15 4:05 == 32.3	7/5/15 8:40 == 32.5	7/5/15 13:15 == 32.6
7/4/15 23:35 == 32.3	7/5/15 4:10 == 32.5	7/5/15 8:45 == 32.5	7/5/15 13:20 == 32.9
7/4/15 23:40 == 32.3	7/5/15 4:15 == 32.2	7/5/15 8:50 == 32.6	7/5/15 13:25 == 32.9
7/4/15 23:45 == 32.3	7/5/15 4:20 == 32.3	7/5/15 8:55 == 32.7	7/5/15 13:30 == 32.8
7/4/15 23:50 == 32.3	7/5/15 4:25 == 32.4	7/5/15 9:00 == 32.6	7/5/15 13:35 == 32.9
7/4/15 23:55 == 32.3	7/5/15 4:30 == 32.3	7/5/15 9:05 == 32.7	7/5/15 13:40 == 32.8
7/5/15 0:00 == 32.2	7/5/15 4:35 == 32.4	7/5/15 9:10 == 32.7	7/5/15 13:45 == 34.9
7/5/15 0:05 == 32.2	7/5/15 4:40 == 32.2	7/5/15 9:15 == 32.7	7/5/15 13:50 == 46.3
7/5/15 0:10 == 32.1	7/5/15 4:45 == 32.4	7/5/15 9:20 == 32.6	7/5/15 13:55 == 46.6

Pumpback Station Discharge (0364)

7/5/15 14:00 == 46.6	7/5/15 18:35 == 32.1	7/5/15 23:10 == 32.9	7/6/15 3:45 == 32
7/5/15 14:05 == 46.6	7/5/15 18:40 == 32.1	7/5/15 23:15 == 35.1	7/6/15 3:50 == 32.1
7/5/15 14:10 == 46.7	7/5/15 18:45 == 32.2	7/5/15 23:20 == 46.4	7/6/15 3:55 == 32.3
7/5/15 14:15 == 45.8	7/5/15 18:50 == 32.4	7/5/15 23:25 == 46.3	7/6/15 4:00 == 32.2
7/5/15 14:20 == 46.2	7/5/15 18:55 == 32.3	7/5/15 23:30 == 46.3	7/6/15 4:05 == 32.3
7/5/15 14:25 == 46.1	7/5/15 19:00 == 32.4	7/5/15 23:35 == 46.1	7/6/15 4:10 == 32.4
7/5/15 14:30 == 46.2	7/5/15 19:05 == 32.5	7/5/15 23:40 == 46.1	7/6/15 4:15 == 32.3
7/5/15 14:35 == 46	7/5/15 19:10 == 32.4	7/5/15 23:45 == 46.1	7/6/15 4:20 == 32.6
7/5/15 14:40 == 46	7/5/15 19:15 == 32.5	7/5/15 23:50 == 46.1	7/6/15 4:25 == 32.5
7/5/15 14:45 == 38.8	7/5/15 19:20 == 32.6	7/5/15 23:55 == 46	7/6/15 4:30 == 32.5
7/5/15 14:50 == 31.4	7/5/15 19:25 == 32.7	7/6/15 0:00 == 45.9	7/6/15 4:35 == 32.4
7/5/15 14:55 == 31.5	7/5/15 19:30 == 32.6	7/6/15 0:05 == 45.8	7/6/15 4:40 == 32.5
7/5/15 15:00 == 31.8	7/5/15 19:35 == 32.6	7/6/15 0:10 == 45.8	7/6/15 4:45 == 32.5
7/5/15 15:05 == 31.8	7/5/15 19:40 == 32.7	7/6/15 0:15 == 37.5	7/6/15 4:50 == 32.5
7/5/15 15:10 == 31.8	7/5/15 19:45 == 32.7	7/6/15 0:20 == 31.4	7/6/15 4:55 == 32.6
7/5/15 15:15 == 32	7/5/15 19:50 == 32.6	7/6/15 0:25 == 31.5	7/6/15 5:00 == 32.8
7/5/15 15:20 == 32.1	7/5/15 19:55 == 32.7	7/6/15 0:30 == 31.8	7/6/15 5:05 == 32.7
7/5/15 15:25 == 32.1	7/5/15 20:00 == 34.9	7/6/15 0:35 == 31.7	7/6/15 5:10 == 32.5
7/5/15 15:30 == 32	7/5/15 20:05 == 45.8	7/6/15 0:40 == 31.7	7/6/15 5:15 == 32.8
7/5/15 15:35 == 32	7/5/15 20:10 == 45.7	7/6/15 0:45 == 32	7/6/15 5:20 == 32.9
7/5/15 15:40 == 31.9	7/5/15 20:15 == 45.6	7/6/15 0:50 == 32.1	7/6/15 5:25 == 32.9
7/5/15 15:45 == 32.1	7/5/15 20:20 == 45.7	7/6/15 0:55 == 32.1	7/6/15 5:30 == 32.8
7/5/15 15:50 == 32.3	7/5/15 20:25 == 45.6	7/6/15 1:00 == 32.1	7/6/15 5:35 == 32.8
7/5/15 15:55 == 32.3	7/5/15 20:30 == 45.9	7/6/15 1:05 == 32.1	7/6/15 5:40 == 32.9
7/5/15 16:00 == 32.2	7/5/15 20:35 == 45.5	7/6/15 1:10 == 32	7/6/15 5:45 == 34.9
7/5/15 16:05 == 32.3	7/5/15 20:40 == 45.7	7/6/15 1:15 == 32.2	7/6/15 5:50 == 45.9
7/5/15 16:10 == 32.5	7/5/15 20:45 == 45.7	7/6/15 1:20 == 32.2	7/6/15 5:55 == 45.9
7/5/15 16:15 == 32.1	7/5/15 20:50 == 45.7	7/6/15 1:25 == 32.2	7/6/15 6:00 == 46
7/5/15 16:20 == 32.3	7/5/15 20:55 == 45.7	7/6/15 1:30 == 32.3	7/6/15 6:05 == 46.2
7/5/15 16:25 == 32.4	7/5/15 21:00 == 37.8	7/6/15 1:35 == 32.4	7/6/15 6:10 == 46
7/5/15 16:30 == 32.4	7/5/15 21:05 == 31.6	7/6/15 1:40 == 32.4	7/6/15 6:15 == 45.7
7/5/15 16:35 == 32.4	7/5/15 21:10 == 31.7	7/6/15 1:45 == 32.5	7/6/15 6:20 == 46
7/5/15 16:40 == 32.3	7/5/15 21:15 == 31.8	7/6/15 1:50 == 32.7	7/6/15 6:25 == 45.9
7/5/15 16:45 == 32.7	7/5/15 21:20 == 32	7/6/15 1:55 == 32.4	7/6/15 6:30 == 37.9
7/5/15 16:50 == 32.6	7/5/15 21:25 == 32	7/6/15 2:00 == 32.5	7/6/15 6:35 == 31.7
7/5/15 16:55 == 32.6	7/5/15 21:30 == 32.1	7/6/15 2:05 == 32.6	7/6/15 6:40 == 31.6
7/5/15 17:00 == 34.7	7/5/15 21:35 == 32.1	7/6/15 2:10 == 32.6	7/6/15 6:45 == 31.7
7/5/15 17:05 == 45.8	7/5/15 21:40 == 32.1	7/6/15 2:15 == 32.5	7/6/15 6:50 == 31.7
7/5/15 17:10 == 46	7/5/15 21:45 == 32.3	7/6/15 2:20 == 32.7	7/6/15 6:55 == 31.9
7/5/15 17:15 == 45.9	7/5/15 21:50 == 32.3	7/6/15 2:25 == 32.5	7/6/15 7:00 == 32.1
7/5/15 17:20 == 45.8	7/5/15 21:55 == 32.4	7/6/15 2:30 == 35.1	7/6/15 7:05 == 32.2
7/5/15 17:25 == 45.9	7/5/15 22:00 == 32.5	7/6/15 2:35 == 45.6	7/6/15 7:10 == 31.9
7/5/15 17:30 == 46	7/5/15 22:05 == 32.4	7/6/15 2:40 == 46.1	7/6/15 7:15 == 32
7/5/15 17:35 == 45.9	7/5/15 22:10 == 32.4	7/6/15 2:45 == 45.8	7/6/15 7:20 == 31.8
7/5/15 17:40 == 45.9	7/5/15 22:15 == 32.5	7/6/15 2:50 == 45.9	7/6/15 7:25 == 32.1
7/5/15 17:45 == 45.9	7/5/15 22:20 == 32.6	7/6/15 2:55 == 46	7/6/15 7:30 == 31.7
7/5/15 17:50 == 45.9	7/5/15 22:25 == 32.8	7/6/15 3:00 == 46	7/6/15 7:35 == 31.7
7/5/15 17:55 == 45.8	7/5/15 22:30 == 32.8	7/6/15 3:05 == 45.9	7/6/15 7:40 == 31.8
7/5/15 18:00 == 38	7/5/15 22:35 == 32.6	7/6/15 3:10 == 45.8	7/6/15 7:45 == 31.9
7/5/15 18:05 == 31.4	7/5/15 22:40 == 32.9	7/6/15 3:15 == 37.8	7/6/15 7:50 == 32.2
7/5/15 18:10 == 31.6	7/5/15 22:45 == 32.7	7/6/15 3:20 == 31.5	7/6/15 7:55 == 32.1
7/5/15 18:15 == 31.8	7/5/15 22:50 == 32.8	7/6/15 3:25 == 31.8	7/6/15 8:00 == 32.3
7/5/15 18:20 == 32.1	7/5/15 22:55 == 32.9	7/6/15 3:30 == 31.7	7/6/15 8:05 == 32
7/5/15 18:25 == 32.1	7/5/15 23:00 == 32.7	7/6/15 3:35 == 31.8	7/6/15 8:10 == 32.5
7/5/15 18:30 == 32.2	7/5/15 23:05 == 32.9	7/6/15 3:40 == 31.8	7/6/15 8:15 == 32

Pumpback Station Discharge (0364)

7/6/15 8:20 == 32.3	7/6/15 12:55 == 46.9	7/6/15 17:30 == 46.3	7/6/15 22:05 == 32.4
7/6/15 8:25 == 32.3	7/6/15 13:00 == 46.9	7/6/15 17:35 == 46.5	7/6/15 22:10 == 32.4
7/6/15 8:30 == 32.3	7/6/15 13:05 == 46.6	7/6/15 17:40 == 46.4	7/6/15 22:15 == 32.7
7/6/15 8:35 == 32.4	7/6/15 13:10 == 46.6	7/6/15 17:45 == 46.2	7/6/15 22:20 == 32.7
7/6/15 8:40 == 32.6	7/6/15 13:15 == 37.5	7/6/15 17:50 == 46.3	7/6/15 22:25 == 32.8
7/6/15 8:45 == 32.4	7/6/15 13:20 == 31.8	7/6/15 17:55 == 46.2	7/6/15 22:30 == 32.8
7/6/15 8:50 == 32.5	7/6/15 13:25 == 31.7	7/6/15 18:00 == 46.3	7/6/15 22:35 == 32.9
7/6/15 8:55 == 32.6	7/6/15 13:30 == 32.1	7/6/15 18:05 == 46.1	7/6/15 22:40 == 32.8
7/6/15 9:00 == 32.7	7/6/15 13:35 == 32.5	7/6/15 18:10 == 46.3	7/6/15 22:45 == 32.9
7/6/15 9:05 == 32.5	7/6/15 13:40 == 32.4	7/6/15 18:15 == 46.1	7/6/15 22:50 == 32.9
7/6/15 9:10 == 32.7	7/6/15 13:45 == 32.4	7/6/15 18:20 == 46.1	7/6/15 22:55 == 32.9
7/6/15 9:15 == 32.5	7/6/15 13:50 == 32.7	7/6/15 18:25 == 46	7/6/15 23:00 == 36.3
7/6/15 9:20 == 32.6	7/6/15 13:55 == 32.5	7/6/15 18:30 == 36.4	7/6/15 23:05 == 46.4
7/6/15 9:25 == 32.7	7/6/15 14:00 == 32.6	7/6/15 18:35 == 31.5	7/6/15 23:10 == 46.3
7/6/15 9:30 == 32.5	7/6/15 14:05 == 32.9	7/6/15 18:40 == 31.4	7/6/15 23:15 == 46.3
7/6/15 9:35 == 32.6	7/6/15 14:10 == 33	7/6/15 18:45 == 31.8	7/6/15 23:20 == 46
7/6/15 9:40 == 32.8	7/6/15 14:15 == 33	7/6/15 18:50 == 32	7/6/15 23:25 == 46
7/6/15 9:45 == 32.7	7/6/15 14:20 == 32.9	7/6/15 18:55 == 32.1	7/6/15 23:30 == 46.1
7/6/15 9:50 == 32.9	7/6/15 14:25 == 33.1	7/6/15 19:00 == 32.2	7/6/15 23:35 == 46.1
7/6/15 9:55 == 32.7	7/6/15 14:30 == 35.3	7/6/15 19:05 == 32.2	7/6/15 23:40 == 46
7/6/15 10:00 == 32.8	7/6/15 14:35 == 47.5	7/6/15 19:10 == 32.3	7/6/15 23:45 == 46.1
7/6/15 10:05 == 33.1	7/6/15 14:40 == 47.3	7/6/15 19:15 == 32.4	7/6/15 23:50 == 46.1
7/6/15 10:10 == 32.8	7/6/15 14:45 == 46.8	7/6/15 19:20 == 32.5	7/6/15 23:55 == 45.8
7/6/15 10:15 == 32.7	7/6/15 14:50 == 47.1	7/6/15 19:25 == 32.5	7/7/15 0:00 == 36.3
7/6/15 10:20 == 32.9	7/6/15 14:55 == 47.2	7/6/15 19:30 == 32.5	7/7/15 0:05 == 31.4
7/6/15 10:25 == 32.7	7/6/15 15:00 == 46.5	7/6/15 19:35 == 32.4	7/7/15 0:10 == 31.4
7/6/15 10:30 == 32.9	7/6/15 15:05 == 46.7	7/6/15 19:40 == 32.4	7/7/15 0:15 == 31.7
7/6/15 10:35 == 32.7	7/6/15 15:10 == 46.7	7/6/15 19:45 == 32.6	7/7/15 0:20 == 31.9
7/6/15 10:40 == 32.8	7/6/15 15:15 == 46.7	7/6/15 19:50 == 32.9	7/7/15 0:25 == 31.9
7/6/15 10:45 == 32.9	7/6/15 15:20 == 46.8	7/6/15 19:55 == 32.8	7/7/15 0:30 == 32.1
7/6/15 10:50 == 32.9	7/6/15 15:25 == 47.1	7/6/15 20:00 == 36.1	7/7/15 0:35 == 32.1
7/6/15 10:55 == 32.7	7/6/15 15:30 == 37.3	7/6/15 20:05 == 46.3	7/7/15 0:40 == 32.2
7/6/15 11:00 == 33	7/6/15 15:35 == 31.8	7/6/15 20:10 == 46.2	7/7/15 0:45 == 32.3
7/6/15 11:05 == 33.1	7/6/15 15:40 == 31.9	7/6/15 20:15 == 46.1	7/7/15 0:50 == 32.5
7/6/15 11:10 == 33.1	7/6/15 15:45 == 32.3	7/6/15 20:20 == 46.2	7/7/15 0:55 == 32.4
7/6/15 11:15 == 35.7	7/6/15 15:50 == 32.1	7/6/15 20:25 == 46.2	7/7/15 1:00 == 32.5
7/6/15 11:20 == 46.8	7/6/15 15:55 == 32	7/6/15 20:30 == 46.1	7/7/15 1:05 == 32.7
7/6/15 11:25 == 46.9	7/6/15 16:00 == 32.3	7/6/15 20:35 == 46.1	7/7/15 1:10 == 32.7
7/6/15 11:30 == 46.4	7/6/15 16:05 == 32.4	7/6/15 20:40 == 46.2	7/7/15 1:15 == 32.7
7/6/15 11:35 == 46.6	7/6/15 16:10 == 32.5	7/6/15 20:45 == 46.1	7/7/15 1:20 == 32.7
7/6/15 11:40 == 46.6	7/6/15 16:15 == 32.3	7/6/15 20:50 == 46.1	7/7/15 1:25 == 32.6
7/6/15 11:45 == 46.4	7/6/15 16:20 == 32.7	7/6/15 20:55 == 46.2	7/7/15 1:30 == 32.8
7/6/15 11:50 == 46.6	7/6/15 16:25 == 32.4	7/6/15 21:00 == 36.5	7/7/15 1:35 == 32.8
7/6/15 11:55 == 46.4	7/6/15 16:30 == 32.4	7/6/15 21:05 == 31.6	7/7/15 1:40 == 32.8
7/6/15 12:00 == 46.7	7/6/15 16:35 == 32.8	7/6/15 21:10 == 31.6	7/7/15 1:45 == 32.9
7/6/15 12:05 == 46.6	7/6/15 16:40 == 32.6	7/6/15 21:15 == 31.7	7/7/15 1:50 == 32.9
7/6/15 12:10 == 46.6	7/6/15 16:45 == 32.7	7/6/15 21:20 == 31.8	7/7/15 1:55 == 32.8
7/6/15 12:15 == 46.4	7/6/15 16:50 == 32.7	7/6/15 21:25 == 31.9	7/7/15 2:00 == 36.3
7/6/15 12:20 == 46.5	7/6/15 16:55 == 32.8	7/6/15 21:30 == 32	7/7/15 2:05 == 46.3
7/6/15 12:25 == 46.5	7/6/15 17:00 == 32.8	7/6/15 21:35 == 32.1	7/7/15 2:10 == 46.1
7/6/15 12:30 == 46.5	7/6/15 17:05 == 32.7	7/6/15 21:40 == 32.1	7/7/15 2:15 == 46.1
7/6/15 12:35 == 46.5	7/6/15 17:10 == 32.7	7/6/15 21:45 == 32.4	7/7/15 2:20 == 46.1
7/6/15 12:40 == 46.9	7/6/15 17:15 == 35.1	7/6/15 21:50 == 32.5	7/7/15 2:25 == 46.1
7/6/15 12:45 == 47	7/6/15 17:20 == 46.3	7/6/15 21:55 == 32.4	7/7/15 2:30 == 46.1
7/6/15 12:50 == 46.4	7/6/15 17:25 == 46.9	7/6/15 22:00 == 32.4	7/7/15 2:35 == 46.1

Pumpback Station Discharge (0364)

7/7/15 2:40 == 46.4	7/7/15 7:15 == 32	7/7/15 11:50 == 46.3	7/7/15 16:25 == 46.4
7/7/15 2:45 == 36.5	7/7/15 7:20 == 32.2	7/7/15 11:55 == 46.4	7/7/15 16:30 == 46.3
7/7/15 2:50 == 31.7	7/7/15 7:25 == 32	7/7/15 12:00 == 46.3	7/7/15 16:35 == 46
7/7/15 2:55 == 31.7	7/7/15 7:30 == 32.6	7/7/15 12:05 == 46.4	7/7/15 16:40 == 45.9
7/7/15 3:00 == 32.1	7/7/15 7:35 == 32.2	7/7/15 12:10 == 46.2	7/7/15 16:45 == 46.1
7/7/15 3:05 == 32.1	7/7/15 7:40 == 32.1	7/7/15 12:15 == 46.1	7/7/15 16:50 == 46
7/7/15 3:10 == 32.1	7/7/15 7:45 == 32.5	7/7/15 12:20 == 46.2	7/7/15 16:55 == 46.1
7/7/15 3:15 == 32.2	7/7/15 7:50 == 32.4	7/7/15 12:25 == 46.1	7/7/15 17:00 == 46
7/7/15 3:20 == 32.2	7/7/15 7:55 == 32.6	7/7/15 12:30 == 46.3	7/7/15 17:05 == 46.2
7/7/15 3:25 == 32.2	7/7/15 8:00 == 33.1	7/7/15 12:35 == 46.2	7/7/15 17:10 == 45.7
7/7/15 3:30 == 32.4	7/7/15 8:05 == 32.7	7/7/15 12:40 == 46.4	7/7/15 17:15 == 46
7/7/15 3:35 == 32.4	7/7/15 8:10 == 33.1	7/7/15 12:45 == 46.3	7/7/15 17:20 == 45.7
7/7/15 3:40 == 32.4	7/7/15 8:15 == 36.9	7/7/15 12:50 == 46.2	7/7/15 17:25 == 46.4
7/7/15 3:45 == 32.6	7/7/15 8:20 == 46.8	7/7/15 12:55 == 46.3	7/7/15 17:30 == 45.8
7/7/15 3:50 == 32.5	7/7/15 8:25 == 46.9	7/7/15 13:00 == 46.5	7/7/15 17:35 == 46
7/7/15 3:55 == 32.5	7/7/15 8:30 == 46.7	7/7/15 13:05 == 46.1	7/7/15 17:40 == 45.9
7/7/15 4:00 == 32.6	7/7/15 8:35 == 46.8	7/7/15 13:10 == 46.6	7/7/15 17:45 == 46.1
7/7/15 4:05 == 32.6	7/7/15 8:40 == 46.9	7/7/15 13:15 == 46.2	7/7/15 17:50 == 46.1
7/7/15 4:10 == 32.6	7/7/15 8:45 == 46.8	7/7/15 13:20 == 46.4	7/7/15 17:55 == 45.7
7/7/15 4:15 == 32.8	7/7/15 8:50 == 46.7	7/7/15 13:25 == 46.8	7/7/15 18:00 == 46
7/7/15 4:20 == 32.7	7/7/15 8:55 == 46.8	7/7/15 13:30 == 46.7	7/7/15 18:05 == 45.9
7/7/15 4:25 == 32.9	7/7/15 9:00 == 47	7/7/15 13:35 == 46.9	7/7/15 18:10 == 46.4
7/7/15 4:30 == 32.8	7/7/15 9:05 == 46.6	7/7/15 13:40 == 46.3	7/7/15 18:15 == 46.3
7/7/15 4:35 == 32.7	7/7/15 9:10 == 46.7	7/7/15 13:45 == 46.1	7/7/15 18:20 == 46.3
7/7/15 4:40 == 32.8	7/7/15 9:15 == 47	7/7/15 13:50 == 46.8	7/7/15 18:25 == 46.4
7/7/15 4:45 == 33	7/7/15 9:20 == 46.6	7/7/15 13:55 == 46.8	7/7/15 18:30 == 46.4
7/7/15 4:50 == 32.8	7/7/15 9:25 == 46.5	7/7/15 14:00 == 46.7	7/7/15 18:35 == 46.4
7/7/15 4:55 == 32.9	7/7/15 9:30 == 46.7	7/7/15 14:05 == 47.2	7/7/15 18:40 == 46.4
7/7/15 5:00 == 36.3	7/7/15 9:35 == 46.5	7/7/15 14:10 == 47	7/7/15 18:45 == 46.4
7/7/15 5:05 == 46.3	7/7/15 9:40 == 46.5	7/7/15 14:15 == 46.8	7/7/15 18:50 == 46.4
7/7/15 5:10 == 46.2	7/7/15 9:45 == 46.5	7/7/15 14:20 == 46.5	7/7/15 18:55 == 46.4
7/7/15 5:15 == 46.1	7/7/15 9:50 == 46.7	7/7/15 14:25 == 47	7/7/15 19:00 == 46.3
7/7/15 5:20 == 46.4	7/7/15 9:55 == 46.6	7/7/15 14:30 == 46.8	7/7/15 19:05 == 46.4
7/7/15 5:25 == 46.5	7/7/15 10:00 == 46.6	7/7/15 14:35 == 46.9	7/7/15 19:10 == 45.9
7/7/15 5:30 == 45.9	7/7/15 10:05 == 46.6	7/7/15 14:40 == 47	7/7/15 19:15 == 45.8
7/7/15 5:35 == 46.3	7/7/15 10:10 == 46.6	7/7/15 14:45 == 46.8	7/7/15 19:20 == 45.7
7/7/15 5:40 == 46	7/7/15 10:15 == 46.8	7/7/15 14:50 == 46.7	7/7/15 19:25 == 45.8
7/7/15 5:45 == 46	7/7/15 10:20 == 46.6	7/7/15 14:55 == 46.9	7/7/15 19:30 == 45.7
7/7/15 5:50 == 46.2	7/7/15 10:25 == 46.6	7/7/15 15:00 == 46.3	7/7/15 19:35 == 45.6
7/7/15 5:55 == 46.1	7/7/15 10:30 == 46.4	7/7/15 15:05 == 46.8	7/7/15 19:40 == 45.9
7/7/15 6:00 == 36.2	7/7/15 10:35 == 46.8	7/7/15 15:10 == 46.6	7/7/15 19:45 == 46
7/7/15 6:05 == 31.5	7/7/15 10:40 == 46.7	7/7/15 15:15 == 46.7	7/7/15 19:50 == 45.9
7/7/15 6:10 == 31.7	7/7/15 10:45 == 46.5	7/7/15 15:20 == 46.2	7/7/15 19:55 == 45.8
7/7/15 6:15 == 31.8	7/7/15 10:50 == 46.3	7/7/15 15:25 == 46.3	7/7/15 20:00 == 45.9
7/7/15 6:20 == 31.7	7/7/15 10:55 == 46.2	7/7/15 15:30 == 46	7/7/15 20:05 == 45.7
7/7/15 6:25 == 31.9	7/7/15 11:00 == 46.4	7/7/15 15:35 == 46.8	7/7/15 20:10 == 46
7/7/15 6:30 == 32	7/7/15 11:05 == 46.5	7/7/15 15:40 == 46.7	7/7/15 20:15 == 45.8
7/7/15 6:35 == 31.9	7/7/15 11:10 == 46.6	7/7/15 15:45 == 46.3	7/7/15 20:20 == 45.7
7/7/15 6:40 == 32	7/7/15 11:15 == 46.7	7/7/15 15:50 == 46.5	7/7/15 20:25 == 46
7/7/15 6:45 == 31.9	7/7/15 11:20 == 46	7/7/15 15:55 == 46.3	7/7/15 20:30 == 46.1
7/7/15 6:50 == 32	7/7/15 11:25 == 46.5	7/7/15 16:00 == 46.4	7/7/15 20:35 == 46
7/7/15 6:55 == 31.9	7/7/15 11:30 == 46.1	7/7/15 16:05 == 46.3	7/7/15 20:40 == 46.1
7/7/15 7:00 == 31.9	7/7/15 11:35 == 46.3	7/7/15 16:10 == 46.3	7/7/15 20:45 == 46
7/7/15 7:05 == 32	7/7/15 11:40 == 46.2	7/7/15 16:15 == 46.4	7/7/15 20:50 == 46.2
7/7/15 7:10 == 32	7/7/15 11:45 == 46.4	7/7/15 16:20 == 46.3	7/7/15 20:55 == 46.1

Pumpback Station Discharge (0364)

7/7/15 21:00 == 46.3	7/8/15 1:35 == 32.8	7/8/15 6:10 == 45.6	7/8/15 10:45 == 46
7/7/15 21:05 == 46.3	7/8/15 1:40 == 32.7	7/8/15 6:15 == 46.3	7/8/15 10:50 == 46.1
7/7/15 21:10 == 46	7/8/15 1:45 == 37.6	7/8/15 6:20 == 46	7/8/15 10:55 == 46.1
7/7/15 21:15 == 46.2	7/8/15 1:50 == 46.7	7/8/15 6:25 == 46.4	7/8/15 11:00 == 46.4
7/7/15 21:20 == 45.7	7/8/15 1:55 == 46.1	7/8/15 6:30 == 46.5	7/8/15 11:05 == 46.1
7/7/15 21:25 == 46.1	7/8/15 2:00 == 46.3	7/8/15 6:35 == 46.1	7/8/15 11:10 == 46.4
7/7/15 21:30 == 46	7/8/15 2:05 == 46.3	7/8/15 6:40 == 45.7	7/8/15 11:15 == 46.1
7/7/15 21:35 == 46	7/8/15 2:10 == 46.1	7/8/15 6:45 == 34.6	7/8/15 11:20 == 46.2
7/7/15 21:40 == 45.9	7/8/15 2:15 == 46	7/8/15 6:50 == 31.8	7/8/15 11:25 == 46.1
7/7/15 21:45 == 45.9	7/8/15 2:20 == 46.1	7/8/15 6:55 == 31.6	7/8/15 11:30 == 46
7/7/15 21:50 == 45.9	7/8/15 2:25 == 46.1	7/8/15 7:00 == 32	7/8/15 11:35 == 46.2
7/7/15 21:55 == 45.4	7/8/15 2:30 == 46.2	7/8/15 7:05 == 32.1	7/8/15 11:40 == 46
7/7/15 22:00 == 45.7	7/8/15 2:35 == 46.2	7/8/15 7:10 == 32.2	7/8/15 11:45 == 46.2
7/7/15 22:05 == 45.5	7/8/15 2:40 == 46.3	7/8/15 7:15 == 32.2	7/8/15 11:50 == 46.1
7/7/15 22:10 == 46	7/8/15 2:45 == 45.8	7/8/15 7:20 == 32.4	7/8/15 11:55 == 46.6
7/7/15 22:15 == 45.8	7/8/15 2:50 == 46.4	7/8/15 7:25 == 32.2	7/8/15 12:00 == 46.1
7/7/15 22:20 == 46.2	7/8/15 2:55 == 46.2	7/8/15 7:30 == 32.5	7/8/15 12:05 == 46.2
7/7/15 22:25 == 46.2	7/8/15 3:00 == 46.3	7/8/15 7:35 == 32.7	7/8/15 12:10 == 45.9
7/7/15 22:30 == 46.1	7/8/15 3:05 == 46.5	7/8/15 7:40 == 32.3	7/8/15 12:15 == 46.2
7/7/15 22:35 == 46.2	7/8/15 3:10 == 46.3	7/8/15 7:45 == 32.8	7/8/15 12:20 == 46.2
7/7/15 22:40 == 46.1	7/8/15 3:15 == 46.4	7/8/15 7:50 == 32.6	7/8/15 12:25 == 45.6
7/7/15 22:45 == 46.2	7/8/15 3:20 == 46.1	7/8/15 7:55 == 32.8	7/8/15 12:30 == 45.7
7/7/15 22:50 == 46	7/8/15 3:25 == 46.3	7/8/15 8:00 == 32.9	7/8/15 12:35 == 45.8
7/7/15 22:55 == 45.9	7/8/15 3:30 == 46.4	7/8/15 8:05 == 32.9	7/8/15 12:40 == 46.1
7/7/15 23:00 == 45.7	7/8/15 3:35 == 46.2	7/8/15 8:10 == 32.9	7/8/15 12:45 == 45.5
7/7/15 23:05 == 45.9	7/8/15 3:40 == 45.8	7/8/15 8:15 == 38	7/8/15 12:50 == 45.7
7/7/15 23:10 == 46	7/8/15 3:45 == 45.9	7/8/15 8:20 == 46.9	7/8/15 12:55 == 45.8
7/7/15 23:15 == 46	7/8/15 3:50 == 46.3	7/8/15 8:25 == 46.2	7/8/15 13:00 == 46.2
7/7/15 23:20 == 45.6	7/8/15 3:55 == 46.2	7/8/15 8:30 == 46.7	7/8/15 13:05 == 46.4
7/7/15 23:25 == 45.9	7/8/15 4:00 == 46.2	7/8/15 8:35 == 46.9	7/8/15 13:10 == 46.3
7/7/15 23:30 == 45.9	7/8/15 4:05 == 46.3	7/8/15 8:40 == 47	7/8/15 13:15 == 46
7/7/15 23:35 == 46	7/8/15 4:10 == 46.3	7/8/15 8:45 == 46.5	7/8/15 13:20 == 46.2
7/7/15 23:40 == 45.9	7/8/15 4:15 == 46.2	7/8/15 8:50 == 46.7	7/8/15 13:25 == 46
7/7/15 23:45 == 45.9	7/8/15 4:20 == 46.4	7/8/15 8:55 == 46.7	7/8/15 13:30 == 46.5
7/7/15 23:50 == 45.9	7/8/15 4:25 == 46.3	7/8/15 9:00 == 46.8	7/8/15 13:35 == 46.6
7/7/15 23:55 == 45.5	7/8/15 4:30 == 46.3	7/8/15 9:05 == 46.8	7/8/15 13:40 == 46.3
7/8/15 0:00 == 45.5	7/8/15 4:35 == 46.2	7/8/15 9:10 == 46.6	7/8/15 13:45 == 46.9
7/8/15 0:05 == 45.5	7/8/15 4:40 == 46	7/8/15 9:15 == 46.9	7/8/15 13:50 == 47
7/8/15 0:10 == 46.1	7/8/15 4:45 == 45.7	7/8/15 9:20 == 47.2	7/8/15 13:55 == 46.8
7/8/15 0:15 == 45.8	7/8/15 4:50 == 46	7/8/15 9:25 == 46.3	7/8/15 14:00 == 46.8
7/8/15 0:20 == 46.3	7/8/15 4:55 == 46.2	7/8/15 9:30 == 46.8	7/8/15 14:05 == 47
7/8/15 0:25 == 46.1	7/8/15 5:00 == 45.9	7/8/15 9:35 == 47.1	7/8/15 14:10 == 46.7
7/8/15 0:30 == 46.3	7/8/15 5:05 == 46.6	7/8/15 9:40 == 46.8	7/8/15 14:15 == 46.7
7/8/15 0:35 == 46.3	7/8/15 5:10 == 46.1	7/8/15 9:45 == 46.8	7/8/15 14:20 == 46.5
7/8/15 0:40 == 46.2	7/8/15 5:15 == 46.7	7/8/15 9:50 == 46.7	7/8/15 14:25 == 46.7
7/8/15 0:45 == 46.2	7/8/15 5:20 == 46.2	7/8/15 9:55 == 46.7	7/8/15 14:30 == 46.8
7/8/15 0:50 == 46.1	7/8/15 5:25 == 46.6	7/8/15 10:00 == 46.8	7/8/15 14:35 == 46.3
7/8/15 0:55 == 46	7/8/15 5:30 == 46.4	7/8/15 10:05 == 46.8	7/8/15 14:40 == 46.5
7/8/15 1:00 == 34.8	7/8/15 5:35 == 46.6	7/8/15 10:10 == 46.7	7/8/15 14:45 == 46.4
7/8/15 1:05 == 31.9	7/8/15 5:40 == 46.4	7/8/15 10:15 == 46.7	7/8/15 14:50 == 46.5
7/8/15 1:10 == 31.7	7/8/15 5:45 == 46.6	7/8/15 10:20 == 46.8	7/8/15 14:55 == 46.9
7/8/15 1:15 == 32.3	7/8/15 5:50 == 46.5	7/8/15 10:25 == 46	7/8/15 15:00 == 46.1
7/8/15 1:20 == 32.4	7/8/15 5:55 == 46.3	7/8/15 10:30 == 46.3	7/8/15 15:05 == 46.4
7/8/15 1:25 == 32.2	7/8/15 6:00 == 46.4	7/8/15 10:35 == 45.8	7/8/15 15:10 == 46.9
7/8/15 1:30 == 32.7	7/8/15 6:05 == 46.9	7/8/15 10:40 == 46.1	7/8/15 15:15 == 46.7

Pumpback Station Discharge (0364)

7/8/15 15:20 == 46.3	7/8/15 19:55 == 46.2	7/9/15 0:30 == 46.1	7/9/15 5:05 == 46.3
7/8/15 15:25 == 46.5	7/8/15 20:00 == 46.3	7/9/15 0:35 == 46.1	7/9/15 5:10 == 46.5
7/8/15 15:30 == 46.3	7/8/15 20:05 == 46.3	7/9/15 0:40 == 46.2	7/9/15 5:15 == 46.2
7/8/15 15:35 == 46.4	7/8/15 20:10 == 46.1	7/9/15 0:45 == 46.1	7/9/15 5:20 == 46.2
7/8/15 15:40 == 46.8	7/8/15 20:15 == 46.3	7/9/15 0:50 == 46.2	7/9/15 5:25 == 46.4
7/8/15 15:45 == 46.3	7/8/15 20:20 == 46.1	7/9/15 0:55 == 46.2	7/9/15 5:30 == 46.6
7/8/15 15:50 == 46.3	7/8/15 20:25 == 46.5	7/9/15 1:00 == 46.2	7/9/15 5:35 == 46.2
7/8/15 15:55 == 46.4	7/8/15 20:30 == 46.4	7/9/15 1:05 == 46.1	7/9/15 5:40 == 46.1
7/8/15 16:00 == 46.5	7/8/15 20:35 == 46.3	7/9/15 1:10 == 46.1	7/9/15 5:45 == 46.1
7/8/15 16:05 == 46.5	7/8/15 20:40 == 46.5	7/9/15 1:15 == 46.2	7/9/15 5:50 == 46.4
7/8/15 16:10 == 46.6	7/8/15 20:45 == 46.4	7/9/15 1:20 == 46.2	7/9/15 5:55 == 46
7/8/15 16:15 == 46.3	7/8/15 20:50 == 46.4	7/9/15 1:25 == 46.1	7/9/15 6:00 == 46.1
7/8/15 16:20 == 46.5	7/8/15 20:55 == 46.2	7/9/15 1:30 == 46.2	7/9/15 6:05 == 46.4
7/8/15 16:25 == 46.4	7/8/15 21:00 == 46.4	7/9/15 1:35 == 46	7/9/15 6:10 == 46.2
7/8/15 16:30 == 46.1	7/8/15 21:05 == 46.3	7/9/15 1:40 == 46	7/9/15 6:15 == 46.5
7/8/15 16:35 == 46.1	7/8/15 21:10 == 46.4	7/9/15 1:45 == 46.1	7/9/15 6:20 == 46
7/8/15 16:40 == 46.2	7/8/15 21:15 == 46.3	7/9/15 1:50 == 46.2	7/9/15 6:25 == 46.8
7/8/15 16:45 == 46.2	7/8/15 21:20 == 46.3	7/9/15 1:55 == 46	7/9/15 6:30 == 46
7/8/15 16:50 == 46	7/8/15 21:25 == 46.1	7/9/15 2:00 == 46	7/9/15 6:35 == 46.4
7/8/15 16:55 == 46.2	7/8/15 21:30 == 46.4	7/9/15 2:05 == 46.2	7/9/15 6:40 == 46.4
7/8/15 17:00 == 46.1	7/8/15 21:35 == 46.1	7/9/15 2:10 == 46	7/9/15 6:45 == 33
7/8/15 17:05 == 46.1	7/8/15 21:40 == 46.2	7/9/15 2:15 == 46.1	7/9/15 6:50 == 31.5
7/8/15 17:10 == 46.2	7/8/15 21:45 == 46.1	7/9/15 2:20 == 46	7/9/15 6:55 == 31.7
7/8/15 17:15 == 46.1	7/8/15 21:50 == 46.2	7/9/15 2:25 == 46.1	7/9/15 7:00 == 31.7
7/8/15 17:20 == 46.2	7/8/15 21:55 == 46.2	7/9/15 2:30 == 46.1	7/9/15 7:05 == 32
7/8/15 17:25 == 46.2	7/8/15 22:00 == 46.2	7/9/15 2:35 == 46.1	7/9/15 7:10 == 31.9
7/8/15 17:30 == 46.1	7/8/15 22:05 == 46.2	7/9/15 2:40 == 46	7/9/15 7:15 == 32.2
7/8/15 17:35 == 46.2	7/8/15 22:10 == 46.1	7/9/15 2:45 == 46.1	7/9/15 7:20 == 32.2
7/8/15 17:40 == 46.1	7/8/15 22:15 == 46.1	7/9/15 2:50 == 46.2	7/9/15 7:25 == 32.2
7/8/15 17:45 == 46.1	7/8/15 22:20 == 46.4	7/9/15 2:55 == 46.1	7/9/15 7:30 == 32.7
7/8/15 17:50 == 46.2	7/8/15 22:25 == 46.2	7/9/15 3:00 == 46.1	7/9/15 7:35 == 32.4
7/8/15 17:55 == 46.3	7/8/15 22:30 == 46.3	7/9/15 3:05 == 46	7/9/15 7:40 == 32.4
7/8/15 18:00 == 46.3	7/8/15 22:35 == 46.4	7/9/15 3:10 == 46.2	7/9/15 7:45 == 32.7
7/8/15 18:05 == 46.3	7/8/15 22:40 == 46.5	7/9/15 3:15 == 46.1	7/9/15 7:50 == 32.7
7/8/15 18:10 == 46.4	7/8/15 22:45 == 46.3	7/9/15 3:20 == 46.1	7/9/15 7:55 == 32.8
7/8/15 18:15 == 46.3	7/8/15 22:50 == 46.3	7/9/15 3:25 == 46.1	7/9/15 8:00 == 32.8
7/8/15 18:20 == 46.4	7/8/15 22:55 == 46.3	7/9/15 3:30 == 46.2	7/9/15 8:05 == 33.1
7/8/15 18:25 == 46.4	7/8/15 23:00 == 46.3	7/9/15 3:35 == 46.1	7/9/15 8:10 == 32.9
7/8/15 18:30 == 46.3	7/8/15 23:05 == 46.3	7/9/15 3:40 == 46	7/9/15 8:15 == 40.1
7/8/15 18:35 == 46.5	7/8/15 23:10 == 46.7	7/9/15 3:45 == 46	7/9/15 8:20 == 47.1
7/8/15 18:40 == 46.5	7/8/15 23:15 == 46.3	7/9/15 3:50 == 46	7/9/15 8:25 == 46.8
7/8/15 18:45 == 46.3	7/8/15 23:20 == 46.3	7/9/15 3:55 == 46.1	7/9/15 8:30 == 46.9
7/8/15 18:50 == 46.5	7/8/15 23:25 == 46.3	7/9/15 4:00 == 46.2	7/9/15 8:35 == 47.1
7/8/15 18:55 == 46.4	7/8/15 23:30 == 46.3	7/9/15 4:05 == 46.3	7/9/15 8:40 == 46.8
7/8/15 19:00 == 46.5	7/8/15 23:35 == 46.3	7/9/15 4:10 == 46.1	7/9/15 8:45 == 47.1
7/8/15 19:05 == 46.4	7/8/15 23:40 == 46.3	7/9/15 4:15 == 46.2	7/9/15 8:50 == 46.6
7/8/15 19:10 == 46.5	7/8/15 23:45 == 46.3	7/9/15 4:20 == 46.2	7/9/15 8:55 == 46.8
7/8/15 19:15 == 46.1	7/8/15 23:50 == 46.3	7/9/15 4:25 == 46.4	7/9/15 9:00 == 47
7/8/15 19:20 == 46.3	7/8/15 23:55 == 46.3	7/9/15 4:30 == 46.4	7/9/15 9:05 == 46.9
7/8/15 19:25 == 46.2	7/9/15 0:00 == 46.2	7/9/15 4:35 == 46.3	7/9/15 9:10 == 47.1
7/8/15 19:30 == 46.3	7/9/15 0:05 == 46.2	7/9/15 4:40 == 46.2	7/9/15 9:15 == 47.1
7/8/15 19:35 == 46.1	7/9/15 0:10 == 46	7/9/15 4:45 == 46.2	7/9/15 9:20 == 47.2
7/8/15 19:40 == 46.1	7/9/15 0:15 == 46.2	7/9/15 4:50 == 46.1	7/9/15 9:25 == 47.1
7/8/15 19:45 == 46.2	7/9/15 0:20 == 46.1	7/9/15 4:55 == 46.5	7/9/15 9:30 == 46.9
7/8/15 19:50 == 46.2	7/9/15 0:25 == 46.2	7/9/15 5:00 == 46.2	7/9/15 9:35 == 47

Pumpback Station Discharge (0364)

7/9/15 9:40 == 46.7	7/9/15 14:15 == 46.9	7/9/15 18:50 == 46.4	7/9/15 23:25 == 46.2
7/9/15 9:45 == 46.9	7/9/15 14:20 == 46.4	7/9/15 18:55 == 46.5	7/9/15 23:30 == 46.2
7/9/15 9:50 == 46.9	7/9/15 14:25 == 46.9	7/9/15 19:00 == 46.3	7/9/15 23:35 == 46.2
7/9/15 9:55 == 47.2	7/9/15 14:30 == 46.8	7/9/15 19:05 == 46.4	7/9/15 23:40 == 46.2
7/9/15 10:00 == 46.7	7/9/15 14:35 == 46.4	7/9/15 19:10 == 46.3	7/9/15 23:45 == 46.2
7/9/15 10:05 == 46.8	7/9/15 14:40 == 46.7	7/9/15 19:15 == 46.4	7/9/15 23:50 == 46.1
7/9/15 10:10 == 46.9	7/9/15 14:45 == 46.8	7/9/15 19:20 == 46.2	7/9/15 23:55 == 46
7/9/15 10:15 == 46.9	7/9/15 14:50 == 46.8	7/9/15 19:25 == 46.1	7/10/15 0:00 == 46
7/9/15 10:20 == 46.9	7/9/15 14:55 == 46.7	7/9/15 19:30 == 46.2	7/10/15 0:05 == 46
7/9/15 10:25 == 46.9	7/9/15 15:00 == 46.4	7/9/15 19:35 == 46.1	7/10/15 0:10 == 46.1
7/9/15 10:30 == 46.9	7/9/15 15:05 == 46.5	7/9/15 19:40 == 46.1	7/10/15 0:15 == 45.9
7/9/15 10:35 == 46.7	7/9/15 15:10 == 46.7	7/9/15 19:45 == 46.3	7/10/15 0:20 == 46
7/9/15 10:40 == 46.9	7/9/15 15:15 == 46.3	7/9/15 19:50 == 46.2	7/10/15 0:25 == 46
7/9/15 10:45 == 47.2	7/9/15 15:20 == 46.9	7/9/15 19:55 == 46.3	7/10/15 0:30 == 46.1
7/9/15 10:50 == 46.7	7/9/15 15:25 == 46.6	7/9/15 20:00 == 46.4	7/10/15 0:35 == 46
7/9/15 10:55 == 47	7/9/15 15:30 == 46.5	7/9/15 20:05 == 46.3	7/10/15 0:40 == 46.1
7/9/15 11:00 == 47.1	7/9/15 15:35 == 46.4	7/9/15 20:10 == 46.3	7/10/15 0:45 == 45.9
7/9/15 11:05 == 47	7/9/15 15:40 == 46.5	7/9/15 20:15 == 46.3	7/10/15 0:50 == 46
7/9/15 11:10 == 47.2	7/9/15 15:45 == 46.6	7/9/15 20:20 == 46.4	7/10/15 0:55 == 46
7/9/15 11:15 == 46.8	7/9/15 15:50 == 46.4	7/9/15 20:25 == 46.3	7/10/15 1:00 == 45.9
7/9/15 11:20 == 46.8	7/9/15 15:55 == 46.6	7/9/15 20:30 == 46.5	7/10/15 1:05 == 46
7/9/15 11:25 == 46.7	7/9/15 16:00 == 46.6	7/9/15 20:35 == 46.4	7/10/15 1:10 == 46.2
7/9/15 11:30 == 46.9	7/9/15 16:05 == 46.5	7/9/15 20:40 == 46.4	7/10/15 1:15 == 46.2
7/9/15 11:35 == 46.8	7/9/15 16:10 == 46.5	7/9/15 20:45 == 46.5	7/10/15 1:20 == 46
7/9/15 11:40 == 47	7/9/15 16:15 == 46.3	7/9/15 20:50 == 46.1	7/10/15 1:25 == 46
7/9/15 11:45 == 46.8	7/9/15 16:20 == 46.3	7/9/15 20:55 == 46.3	7/10/15 1:30 == 45.9
7/9/15 11:50 == 46.8	7/9/15 16:25 == 46.1	7/9/15 21:00 == 46.2	7/10/15 1:35 == 46
7/9/15 11:55 == 47	7/9/15 16:30 == 46.4	7/9/15 21:05 == 46.3	7/10/15 1:40 == 46
7/9/15 12:00 == 47	7/9/15 16:35 == 46.1	7/9/15 21:10 == 46.2	7/10/15 1:45 == 46
7/9/15 12:05 == 47.2	7/9/15 16:40 == 46.1	7/9/15 21:15 == 46.5	7/10/15 1:50 == 45.9
7/9/15 12:10 == 46.7	7/9/15 16:45 == 46.1	7/9/15 21:20 == 46.1	7/10/15 1:55 == 45.8
7/9/15 12:15 == 47	7/9/15 16:50 == 46.1	7/9/15 21:25 == 46.1	7/10/15 2:00 == 46
7/9/15 12:20 == 47	7/9/15 16:55 == 46.2	7/9/15 21:30 == 46.1	7/10/15 2:05 == 45.9
7/9/15 12:25 == 46.9	7/9/15 17:00 == 46	7/9/15 21:35 == 45.9	7/10/15 2:10 == 45.9
7/9/15 12:30 == 46.9	7/9/15 17:05 == 46	7/9/15 21:40 == 46.1	7/10/15 2:15 == 45.9
7/9/15 12:35 == 46.7	7/9/15 17:10 == 46.2	7/9/15 21:45 == 46.2	7/10/15 2:20 == 46
7/9/15 12:40 == 46.9	7/9/15 17:15 == 46.2	7/9/15 21:50 == 45.9	7/10/15 2:25 == 45.9
7/9/15 12:45 == 47.1	7/9/15 17:20 == 46.1	7/9/15 21:55 == 46	7/10/15 2:30 == 32
7/9/15 12:50 == 46.8	7/9/15 17:25 == 46.2	7/9/15 22:00 == 46.1	7/10/15 2:35 == 31.7
7/9/15 12:55 == 47	7/9/15 17:30 == 46.3	7/9/15 22:05 == 46	7/10/15 2:40 == 31.6
7/9/15 13:00 == 46.4	7/9/15 17:35 == 46.1	7/9/15 22:10 == 46.1	7/10/15 2:45 == 32.4
7/9/15 13:05 == 46.7	7/9/15 17:40 == 46.1	7/9/15 22:15 == 46	7/10/15 2:50 == 32.4
7/9/15 13:10 == 46.4	7/9/15 17:45 == 46.2	7/9/15 22:20 == 46.6	7/10/15 2:55 == 32.4
7/9/15 13:15 == 46.5	7/9/15 17:50 == 46.2	7/9/15 22:25 == 46.2	7/10/15 3:00 == 32.8
7/9/15 13:20 == 47	7/9/15 17:55 == 46.1	7/9/15 22:30 == 46.3	7/10/15 3:05 == 32.8
7/9/15 13:25 == 46.6	7/9/15 18:00 == 46.2	7/9/15 22:35 == 46.3	7/10/15 3:10 == 32.9
7/9/15 13:30 == 46.8	7/9/15 18:05 == 46.2	7/9/15 22:40 == 46.3	7/10/15 3:15 == 26.8
7/9/15 13:35 == 46.9	7/9/15 18:10 == 46.6	7/9/15 22:45 == 46.3	7/10/15 3:20 == 26.6
7/9/15 13:40 == 46.6	7/9/15 18:15 == 46.3	7/9/15 22:50 == 46.4	7/10/15 3:25 == 26.7
7/9/15 13:45 == 46.7	7/9/15 18:20 == 46.5	7/9/15 22:55 == 46.4	7/10/15 3:30 == 26.6
7/9/15 13:50 == 46.6	7/9/15 18:25 == 46.4	7/9/15 23:00 == 46.1	7/10/15 3:35 == 26.7
7/9/15 13:55 == 46.7	7/9/15 18:30 == 46.4	7/9/15 23:05 == 46.2	7/10/15 3:40 == 26.6
7/9/15 14:00 == 46.9	7/9/15 18:35 == 46.4	7/9/15 23:10 == 46.5	7/10/15 3:45 == 26.7
7/9/15 14:05 == 46.4	7/9/15 18:40 == 46.4	7/9/15 23:15 == 46.3	7/10/15 3:50 == 27.2
7/9/15 14:10 == 46.8	7/9/15 18:45 == 46.3	7/9/15 23:20 == 46.2	7/10/15 3:55 == 44.9

Pumpback Station Discharge (0364)

7/10/15 4:00 == 46.2	7/10/15 8:35 == 33	7/10/15 13:10 == 46.6	7/10/15 17:45 == 32.8
7/10/15 4:05 == 46.2	7/10/15 8:40 == 32.6	7/10/15 13:15 == 46.7	7/10/15 17:50 == 32.8
7/10/15 4:10 == 46.3	7/10/15 8:45 == 42.1	7/10/15 13:20 == 46.2	7/10/15 17:55 == 32.3
7/10/15 4:15 == 46.3	7/10/15 8:50 == 46.5	7/10/15 13:25 == 46.2	7/10/15 18:00 == 42.2
7/10/15 4:20 == 46.4	7/10/15 8:55 == 46.6	7/10/15 13:30 == 46.4	7/10/15 18:05 == 46.1
7/10/15 4:25 == 46.4	7/10/15 9:00 == 46.6	7/10/15 13:35 == 46.6	7/10/15 18:10 == 46.4
7/10/15 4:30 == 46.3	7/10/15 9:05 == 46.8	7/10/15 13:40 == 46.4	7/10/15 18:15 == 46.3
7/10/15 4:35 == 46.3	7/10/15 9:10 == 46.9	7/10/15 13:45 == 46.6	7/10/15 18:20 == 46.3
7/10/15 4:40 == 46.3	7/10/15 9:15 == 46.6	7/10/15 13:50 == 46.4	7/10/15 18:25 == 46.4
7/10/15 4:45 == 46.1	7/10/15 9:20 == 46.3	7/10/15 13:55 == 46.4	7/10/15 18:30 == 46.4
7/10/15 4:50 == 46.4	7/10/15 9:25 == 46.4	7/10/15 14:00 == 46.7	7/10/15 18:35 == 46.5
7/10/15 4:55 == 46.5	7/10/15 9:30 == 46.4	7/10/15 14:05 == 46.6	7/10/15 18:40 == 46.4
7/10/15 5:00 == 46.6	7/10/15 9:35 == 46.6	7/10/15 14:10 == 46.7	7/10/15 18:45 == 46.4
7/10/15 5:05 == 46.3	7/10/15 9:40 == 46.6	7/10/15 14:15 == 46.6	7/10/15 18:50 == 46.3
7/10/15 5:10 == 46.6	7/10/15 9:45 == 46.7	7/10/15 14:20 == 46.8	7/10/15 18:55 == 46.2
7/10/15 5:15 == 46.4	7/10/15 9:50 == 46.5	7/10/15 14:25 == 46.6	7/10/15 19:00 == 46.5
7/10/15 5:20 == 46.5	7/10/15 9:55 == 46.5	7/10/15 14:30 == 46.8	7/10/15 19:05 == 46.3
7/10/15 5:25 == 46.2	7/10/15 10:00 == 46.7	7/10/15 14:35 == 46.6	7/10/15 19:10 == 46.1
7/10/15 5:30 == 46.4	7/10/15 10:05 == 46.7	7/10/15 14:40 == 46.6	7/10/15 19:15 == 46.5
7/10/15 5:35 == 46.6	7/10/15 10:10 == 46.5	7/10/15 14:45 == 46.6	7/10/15 19:20 == 46.2
7/10/15 5:40 == 46.4	7/10/15 10:15 == 46.6	7/10/15 14:50 == 46.7	7/10/15 19:25 == 46.2
7/10/15 5:45 == 46.2	7/10/15 10:20 == 46.8	7/10/15 14:55 == 46.3	7/10/15 19:30 == 46.2
7/10/15 5:50 == 46.1	7/10/15 10:25 == 46.5	7/10/15 15:00 == 46.3	7/10/15 19:35 == 46.1
7/10/15 5:55 == 46.2	7/10/15 10:30 == 47	7/10/15 15:05 == 46.4	7/10/15 19:40 == 46.1
7/10/15 6:00 == 46.2	7/10/15 10:35 == 46.4	7/10/15 15:10 == 46.9	7/10/15 19:45 == 46.2
7/10/15 6:05 == 46.2	7/10/15 10:40 == 46.8	7/10/15 15:15 == 46.3	7/10/15 19:50 == 46.1
7/10/15 6:10 == 46.5	7/10/15 10:45 == 46.7	7/10/15 15:20 == 46.5	7/10/15 19:55 == 46.1
7/10/15 6:15 == 46.1	7/10/15 10:50 == 46.8	7/10/15 15:25 == 46.3	7/10/15 20:00 == 46.2
7/10/15 6:20 == 46.2	7/10/15 10:55 == 46.6	7/10/15 15:30 == 46	7/10/15 20:05 == 46.2
7/10/15 6:25 == 46.2	7/10/15 11:00 == 47	7/10/15 15:35 == 46.4	7/10/15 20:10 == 46.1
7/10/15 6:30 == 46.3	7/10/15 11:05 == 46.9	7/10/15 15:40 == 46.5	7/10/15 20:15 == 46
7/10/15 6:35 == 46.2	7/10/15 11:10 == 46.8	7/10/15 15:45 == 46.4	7/10/15 20:20 == 46.1
7/10/15 6:40 == 46.3	7/10/15 11:15 == 47	7/10/15 15:50 == 46.4	7/10/15 20:25 == 46.4
7/10/15 6:45 == 46.4	7/10/15 11:20 == 46.5	7/10/15 15:55 == 46.5	7/10/15 20:30 == 46.2
7/10/15 6:50 == 46.4	7/10/15 11:25 == 46.6	7/10/15 16:00 == 46.3	7/10/15 20:35 == 46.3
7/10/15 6:55 == 46.7	7/10/15 11:30 == 46.6	7/10/15 16:05 == 46.4	7/10/15 20:40 == 46.3
7/10/15 7:00 == 46.4	7/10/15 11:35 == 46.9	7/10/15 16:10 == 46.5	7/10/15 20:45 == 46.2
7/10/15 7:05 == 46.5	7/10/15 11:40 == 46.6	7/10/15 16:15 == 46.4	7/10/15 20:50 == 46.2
7/10/15 7:10 == 45.9	7/10/15 11:45 == 47	7/10/15 16:20 == 46.4	7/10/15 20:55 == 46.2
7/10/15 7:15 == 46.1	7/10/15 11:50 == 46.4	7/10/15 16:25 == 46.2	7/10/15 21:00 == 46.3
7/10/15 7:20 == 46.8	7/10/15 11:55 == 46.7	7/10/15 16:30 == 46.3	7/10/15 21:05 == 46.2
7/10/15 7:25 == 46.6	7/10/15 12:00 == 46.8	7/10/15 16:35 == 46.1	7/10/15 21:10 == 45
7/10/15 7:30 == 46.2	7/10/15 12:05 == 47	7/10/15 16:40 == 45.9	7/10/15 21:15 == 31.9
7/10/15 7:35 == 46.5	7/10/15 12:10 == 46.7	7/10/15 16:45 == 46.1	7/10/15 21:20 == 31.6
7/10/15 7:40 == 45.8	7/10/15 12:15 == 46.6	7/10/15 16:50 == 46	7/10/15 21:25 == 31.6
7/10/15 7:45 == 32.1	7/10/15 12:20 == 46.8	7/10/15 16:55 == 45.8	7/10/15 21:30 == 32.2
7/10/15 7:50 == 31.8	7/10/15 12:25 == 47	7/10/15 17:00 == 46	7/10/15 21:35 == 32.3
7/10/15 7:55 == 31.8	7/10/15 12:30 == 46.6	7/10/15 17:05 == 46	7/10/15 21:40 == 32.4
7/10/15 8:00 == 32.5	7/10/15 12:35 == 47	7/10/15 17:10 == 44.7	7/10/15 21:45 == 32.7
7/10/15 8:05 == 32	7/10/15 12:40 == 46.2	7/10/15 17:15 == 32	7/10/15 21:50 == 32.6
7/10/15 8:10 == 32.4	7/10/15 12:45 == 46.3	7/10/15 17:20 == 31.7	7/10/15 21:55 == 32.2
7/10/15 8:15 == 32.5	7/10/15 12:50 == 46.6	7/10/15 17:25 == 31.7	7/10/15 22:00 == 42.3
7/10/15 8:20 == 32.7	7/10/15 12:55 == 46.2	7/10/15 17:30 == 32.5	7/10/15 22:05 == 46
7/10/15 8:25 == 32.5	7/10/15 13:00 == 46.4	7/10/15 17:35 == 32.4	7/10/15 22:10 == 46.1
7/10/15 8:30 == 32.7	7/10/15 13:05 == 46.4	7/10/15 17:40 == 32.4	7/10/15 22:15 == 46

Pumpback Station Discharge (0364)

7/10/15 22:20 == 46.4	7/11/15 2:55 == 32.2	7/11/15 7:30 == 31.7	7/11/15 12:05 == 44.7
7/10/15 22:25 == 46.4	7/11/15 3:00 == 32.5	7/11/15 7:35 == 31.5	7/11/15 12:10 == 44.6
7/10/15 22:30 == 46.3	7/11/15 3:05 == 32.6	7/11/15 7:40 == 31.6	7/11/15 12:15 == 44.5
7/10/15 22:35 == 46.4	7/11/15 3:10 == 32.2	7/11/15 7:45 == 31.8	7/11/15 12:20 == 44.7
7/10/15 22:40 == 46.1	7/11/15 3:15 == 42.5	7/11/15 7:50 == 31.9	7/11/15 12:25 == 45
7/10/15 22:45 == 46.3	7/11/15 3:20 == 46	7/11/15 7:55 == 32.2	7/11/15 12:30 == 44.9
7/10/15 22:50 == 46.4	7/11/15 3:25 == 46.1	7/11/15 8:00 == 32.5	7/11/15 12:35 == 44.8
7/10/15 22:55 == 46.4	7/11/15 3:30 == 46.1	7/11/15 8:05 == 32	7/11/15 12:40 == 44.5
7/10/15 23:00 == 46.3	7/11/15 3:35 == 46.1	7/11/15 8:10 == 32.5	7/11/15 12:45 == 44.4
7/10/15 23:05 == 46.3	7/11/15 3:40 == 46	7/11/15 8:15 == 32.5	7/11/15 12:50 == 44.7
7/10/15 23:10 == 46.6	7/11/15 3:45 == 46	7/11/15 8:20 == 32	7/11/15 12:55 == 44.5
7/10/15 23:15 == 46.2	7/11/15 3:50 == 46	7/11/15 8:25 == 32.4	7/11/15 13:00 == 44.4
7/10/15 23:20 == 46.3	7/11/15 3:55 == 46.2	7/11/15 8:30 == 32.1	7/11/15 13:05 == 44.7
7/10/15 23:25 == 46.3	7/11/15 4:00 == 46.2	7/11/15 8:35 == 32.6	7/11/15 13:10 == 44.5
7/10/15 23:30 == 46.3	7/11/15 4:05 == 46.2	7/11/15 8:40 == 32.2	7/11/15 13:15 == 44.6
7/10/15 23:35 == 46.2	7/11/15 4:10 == 46.2	7/11/15 8:45 == 32.5	7/11/15 13:20 == 44.5
7/10/15 23:40 == 44.9	7/11/15 4:15 == 46.1	7/11/15 8:50 == 32.4	7/11/15 13:25 == 45.2
7/10/15 23:45 == 31.9	7/11/15 4:20 == 46.2	7/11/15 8:55 == 32.6	7/11/15 13:30 == 45.3
7/10/15 23:50 == 31.6	7/11/15 4:25 == 44.7	7/11/15 9:00 == 32.9	7/11/15 13:35 == 45.4
7/10/15 23:55 == 31.6	7/11/15 4:30 == 31.8	7/11/15 9:05 == 32.7	7/11/15 13:40 == 45.4
7/11/15 0:00 == 32.2	7/11/15 4:35 == 31.7	7/11/15 9:10 == 31.8	7/11/15 13:45 == 45.3
7/11/15 0:05 == 32.1	7/11/15 4:40 == 31.6	7/11/15 9:15 == 43.8	7/11/15 13:50 == 45.8
7/11/15 0:10 == 32.1	7/11/15 4:45 == 32	7/11/15 9:20 == 45.9	7/11/15 13:55 == 45.4
7/11/15 0:15 == 32.3	7/11/15 4:50 == 32.2	7/11/15 9:25 == 45.7	7/11/15 14:00 == 45.5
7/11/15 0:20 == 32.4	7/11/15 4:55 == 32.2	7/11/15 9:30 == 46.3	7/11/15 14:05 == 46
7/11/15 0:25 == 32.4	7/11/15 5:00 == 32.5	7/11/15 9:35 == 45.6	7/11/15 14:10 == 45.5
7/11/15 0:30 == 32.7	7/11/15 5:05 == 32.5	7/11/15 9:40 == 45.9	7/11/15 14:15 == 45.8
7/11/15 0:35 == 32.8	7/11/15 5:10 == 32.6	7/11/15 9:45 == 45.7	7/11/15 14:20 == 45.4
7/11/15 0:40 == 32.1	7/11/15 5:15 == 32.8	7/11/15 9:50 == 45.7	7/11/15 14:25 == 45.3
7/11/15 0:45 == 42.6	7/11/15 5:20 == 32.7	7/11/15 9:55 == 45.5	7/11/15 14:30 == 45.3
7/11/15 0:50 == 46	7/11/15 5:25 == 32	7/11/15 10:00 == 45.8	7/11/15 14:35 == 45.4
7/11/15 0:55 == 46	7/11/15 5:30 == 43.5	7/11/15 10:05 == 45.6	7/11/15 14:40 == 42.7
7/11/15 1:00 == 46	7/11/15 5:35 == 46.4	7/11/15 10:10 == 45.8	7/11/15 14:45 == 31.3
7/11/15 1:05 == 45.9	7/11/15 5:40 == 46.3	7/11/15 10:15 == 46.7	7/11/15 14:50 == 31.3
7/11/15 1:10 == 46.1	7/11/15 5:45 == 46.2	7/11/15 10:20 == 46.6	7/11/15 14:55 == 31.5
7/11/15 1:15 == 45.8	7/11/15 5:50 == 46.2	7/11/15 10:25 == 43.6	7/11/15 15:00 == 31.7
7/11/15 1:20 == 46.1	7/11/15 5:55 == 46.2	7/11/15 10:30 == 31.5	7/11/15 15:05 == 31.9
7/11/15 1:25 == 45.9	7/11/15 6:00 == 46.2	7/11/15 10:35 == 31.5	7/11/15 15:10 == 32
7/11/15 1:30 == 45.9	7/11/15 6:05 == 46.1	7/11/15 10:40 == 31.7	7/11/15 15:15 == 32.2
7/11/15 1:35 == 46	7/11/15 6:10 == 46.4	7/11/15 10:45 == 32.5	7/11/15 15:20 == 32.3
7/11/15 1:40 == 45.9	7/11/15 6:15 == 46.2	7/11/15 10:50 == 32.4	7/11/15 15:25 == 32.4
7/11/15 1:45 == 46	7/11/15 6:20 == 46.2	7/11/15 10:55 == 32.5	7/11/15 15:30 == 32
7/11/15 1:50 == 46	7/11/15 6:25 == 46.1	7/11/15 11:00 == 32.7	7/11/15 15:35 == 32.1
7/11/15 1:55 == 46	7/11/15 6:30 == 46.3	7/11/15 11:05 == 32.7	7/11/15 15:40 == 31.3
7/11/15 2:00 == 46.2	7/11/15 6:35 == 46.5	7/11/15 11:10 == 31.7	7/11/15 15:45 == 43.2
7/11/15 2:05 == 46	7/11/15 6:40 == 43.8	7/11/15 11:15 == 44.1	7/11/15 15:50 == 44.8
7/11/15 2:10 == 46	7/11/15 6:45 == 31.4	7/11/15 11:20 == 45.9	7/11/15 15:55 == 44.7
7/11/15 2:15 == 46.1	7/11/15 6:50 == 31.4	7/11/15 11:25 == 45.7	7/11/15 16:00 == 44.8
7/11/15 2:20 == 46	7/11/15 6:55 == 31.5	7/11/15 11:30 == 45.5	7/11/15 16:05 == 44.5
7/11/15 2:25 == 44.7	7/11/15 7:00 == 31.7	7/11/15 11:35 == 45.2	7/11/15 16:10 == 44.7
7/11/15 2:30 == 31.8	7/11/15 7:05 == 31.7	7/11/15 11:40 == 44.9	7/11/15 16:15 == 44.7
7/11/15 2:35 == 31.7	7/11/15 7:10 == 31.2	7/11/15 11:45 == 45	7/11/15 16:20 == 44.7
7/11/15 2:40 == 31.7	7/11/15 7:15 == 31.2	7/11/15 11:50 == 44.8	7/11/15 16:25 == 44.5
7/11/15 2:45 == 32.2	7/11/15 7:20 == 31.3	7/11/15 11:55 == 44.9	7/11/15 16:30 == 44.4
7/11/15 2:50 == 32.2	7/11/15 7:25 == 31.4	7/11/15 12:00 == 44.7	7/11/15 16:35 == 44.4

Pumpback Station Discharge (0364)

7/11/15 16:40 == 44.4	7/11/15 21:15 == 31.8	7/12/15 1:50 == 26.4	7/12/15 6:25 == 45
7/11/15 16:45 == 44.4	7/11/15 21:20 == 31.7	7/12/15 1:55 == 26.4	7/12/15 6:30 == 45
7/11/15 16:50 == 44.5	7/11/15 21:25 == 31.7	7/12/15 2:00 == 26.4	7/12/15 6:35 == 45.1
7/11/15 16:55 == 44.5	7/11/15 21:30 == 31.8	7/12/15 2:05 == 26.4	7/12/15 6:40 == 45
7/11/15 17:00 == 44.4	7/11/15 21:35 == 31.9	7/12/15 2:10 == 26.5	7/12/15 6:45 == 45
7/11/15 17:05 == 44.3	7/11/15 21:40 == 31.9	7/12/15 2:15 == 26.6	7/12/15 6:50 == 45.2
7/11/15 17:10 == 44.3	7/11/15 21:45 == 32.1	7/12/15 2:20 == 26.3	7/12/15 6:55 == 44.9
7/11/15 17:15 == 44.2	7/11/15 21:50 == 32.1	7/12/15 2:25 == 26.4	7/12/15 7:00 == 44.9
7/11/15 17:20 == 44.5	7/11/15 21:55 == 31.1	7/12/15 2:30 == 26.5	7/12/15 7:05 == 45
7/11/15 17:25 == 44.7	7/11/15 22:00 == 26.2	7/12/15 2:35 == 26.3	7/12/15 7:10 == 45
7/11/15 17:30 == 44.4	7/11/15 22:05 == 26.2	7/12/15 2:40 == 26.4	7/12/15 7:15 == 45
7/11/15 17:35 == 44.4	7/11/15 22:10 == 26.2	7/12/15 2:45 == 26.4	7/12/15 7:20 == 44.9
7/11/15 17:40 == 44.4	7/11/15 22:15 == 26.2	7/12/15 2:50 == 26.4	7/12/15 7:25 == 45
7/11/15 17:45 == 44.5	7/11/15 22:20 == 26.4	7/12/15 2:55 == 26.3	7/12/15 7:30 == 44.9
7/11/15 17:50 == 44.5	7/11/15 22:25 == 26.5	7/12/15 3:00 == 26.4	7/12/15 7:35 == 45.1
7/11/15 17:55 == 42	7/11/15 22:30 == 26.4	7/12/15 3:05 == 26.4	7/12/15 7:40 == 45.3
7/11/15 18:00 == 31.1	7/11/15 22:35 == 26.4	7/12/15 3:10 == 26.3	7/12/15 7:45 == 45.5
7/11/15 18:05 == 30.9	7/11/15 22:40 == 26.5	7/12/15 3:15 == 26.3	7/12/15 7:50 == 45.8
7/11/15 18:10 == 31.5	7/11/15 22:45 == 26.3	7/12/15 3:20 == 26.4	7/12/15 7:55 == 45.8
7/11/15 18:15 == 31.6	7/11/15 22:50 == 26.5	7/12/15 3:25 == 26.5	7/12/15 8:00 == 45.8
7/11/15 18:20 == 31.7	7/11/15 22:55 == 26.3	7/12/15 3:30 == 26.4	7/12/15 8:05 == 45.7
7/11/15 18:25 == 31.7	7/11/15 23:00 == 26.5	7/12/15 3:35 == 26.4	7/12/15 8:10 == 45.7
7/11/15 18:30 == 32.1	7/11/15 23:05 == 26.3	7/12/15 3:40 == 26.4	7/12/15 8:15 == 45.9
7/11/15 18:35 == 32	7/11/15 23:10 == 26.5	7/12/15 3:45 == 26.4	7/12/15 8:20 == 45.7
7/11/15 18:40 == 32.1	7/11/15 23:15 == 26.4	7/12/15 3:50 == 26.4	7/12/15 8:25 == 45.5
7/11/15 18:45 == 32.3	7/11/15 23:20 == 26.3	7/12/15 3:55 == 26.4	7/12/15 8:30 == 45.5
7/11/15 18:50 == 32.3	7/11/15 23:25 == 26.6	7/12/15 4:00 == 26.5	7/12/15 8:35 == 45.6
7/11/15 18:55 == 32.4	7/11/15 23:30 == 26.3	7/12/15 4:05 == 26.4	7/12/15 8:40 == 45.9
7/11/15 19:00 == 32.4	7/11/15 23:35 == 26.5	7/12/15 4:10 == 26.4	7/12/15 8:45 == 45.8
7/11/15 19:05 == 32.4	7/11/15 23:40 == 26.4	7/12/15 4:15 == 26.5	7/12/15 8:50 == 45.9
7/11/15 19:10 == 31.3	7/11/15 23:45 == 26.5	7/12/15 4:20 == 26.5	7/12/15 8:55 == 45.8
7/11/15 19:15 == 42.7	7/11/15 23:50 == 26.3	7/12/15 4:25 == 26.5	7/12/15 9:00 == 46
7/11/15 19:20 == 44.6	7/11/15 23:55 == 26.3	7/12/15 4:30 == 26.5	7/12/15 9:05 == 45.9
7/11/15 19:25 == 44.8	7/12/15 0:00 == 26.3	7/12/15 4:35 == 26.6	7/12/15 9:10 == 45.9
7/11/15 19:30 == 44.5	7/12/15 0:05 == 26.3	7/12/15 4:40 == 26.5	7/12/15 9:15 == 45.8
7/11/15 19:35 == 44.5	7/12/15 0:10 == 26.2	7/12/15 4:45 == 26.5	7/12/15 9:20 == 45.8
7/11/15 19:40 == 44.6	7/12/15 0:15 == 26.3	7/12/15 4:50 == 26.6	7/12/15 9:25 == 45.7
7/11/15 19:45 == 44.6	7/12/15 0:20 == 26.2	7/12/15 4:55 == 26.5	7/12/15 9:30 == 45.8
7/11/15 19:50 == 44.7	7/12/15 0:25 == 26.3	7/12/15 5:00 == 26.5	7/12/15 9:35 == 45.7
7/11/15 19:55 == 44.6	7/12/15 0:30 == 26.2	7/12/15 5:05 == 26.5	7/12/15 9:40 == 45.7
7/11/15 20:00 == 44.8	7/12/15 0:35 == 26.3	7/12/15 5:10 == 26.4	7/12/15 9:45 == 45.8
7/11/15 20:05 == 44.6	7/12/15 0:40 == 26.3	7/12/15 5:15 == 26.4	7/12/15 9:50 == 45.7
7/11/15 20:10 == 44.7	7/12/15 0:45 == 26.3	7/12/15 5:20 == 26.5	7/12/15 9:55 == 45.7
7/11/15 20:15 == 44.7	7/12/15 0:50 == 26.4	7/12/15 5:25 == 26.5	7/12/15 10:00 == 45.7
7/11/15 20:20 == 44.7	7/12/15 0:55 == 26.2	7/12/15 5:30 == 26.4	7/12/15 10:05 == 45.9
7/11/15 20:25 == 45	7/12/15 1:00 == 26.3	7/12/15 5:35 == 26.5	7/12/15 10:10 == 45.6
7/11/15 20:30 == 44.8	7/12/15 1:05 == 26.3	7/12/15 5:40 == 26.5	7/12/15 10:15 == 45.7
7/11/15 20:35 == 44.9	7/12/15 1:10 == 26.4	7/12/15 5:45 == 26.4	7/12/15 10:20 == 45.5
7/11/15 20:40 == 44.8	7/12/15 1:15 == 26.3	7/12/15 5:50 == 42.8	7/12/15 10:25 == 45.7
7/11/15 20:45 == 45	7/12/15 1:20 == 26.3	7/12/15 5:55 == 45.3	7/12/15 10:30 == 45.5
7/11/15 20:50 == 45.1	7/12/15 1:25 == 26.5	7/12/15 6:00 == 45	7/12/15 10:35 == 45.6
7/11/15 20:55 == 42.5	7/12/15 1:30 == 26.4	7/12/15 6:05 == 45.1	7/12/15 10:40 == 45.9
7/11/15 21:00 == 31.4	7/12/15 1:35 == 26.4	7/12/15 6:10 == 45.1	7/12/15 10:45 == 45.9
7/11/15 21:05 == 31.2	7/12/15 1:40 == 26.4	7/12/15 6:15 == 45.1	7/12/15 10:50 == 46
7/11/15 21:10 == 31.4	7/12/15 1:45 == 26.4	7/12/15 6:20 == 45.1	7/12/15 10:55 == 45.6

Pumpback Station Discharge (0364)

7/12/15 11:00 == 45.8	7/12/15 15:35 == 44.4	7/12/15 20:10 == 44.5	7/13/15 0:45 == 44.3
7/12/15 11:05 == 45.7	7/12/15 15:40 == 45	7/12/15 20:15 == 44.5	7/13/15 0:50 == 44.3
7/12/15 11:10 == 45.8	7/12/15 15:45 == 44.6	7/12/15 20:20 == 44.5	7/13/15 0:55 == 40
7/12/15 11:15 == 45.5	7/12/15 15:50 == 44.6	7/12/15 20:25 == 44.9	7/13/15 1:00 == 30.9
7/12/15 11:20 == 45.1	7/12/15 15:55 == 44.6	7/12/15 20:30 == 44.7	7/13/15 1:05 == 30.9
7/12/15 11:25 == 44.7	7/12/15 16:00 == 44.8	7/12/15 20:35 == 44.9	7/13/15 1:10 == 31
7/12/15 11:30 == 44.7	7/12/15 16:05 == 44.7	7/12/15 20:40 == 44.8	7/13/15 1:15 == 31.4
7/12/15 11:35 == 44.6	7/12/15 16:10 == 44.6	7/12/15 20:45 == 45	7/13/15 1:20 == 31.3
7/12/15 11:40 == 44.7	7/12/15 16:15 == 44.8	7/12/15 20:50 == 44.9	7/13/15 1:25 == 31.4
7/12/15 11:45 == 44.6	7/12/15 16:20 == 44.6	7/12/15 20:55 == 44.8	7/13/15 1:30 == 31.7
7/12/15 11:50 == 44.5	7/12/15 16:25 == 44.4	7/12/15 21:00 == 44.8	7/13/15 1:35 == 31.7
7/12/15 11:55 == 44.6	7/12/15 16:30 == 44.4	7/12/15 21:05 == 45	7/13/15 1:40 == 31.9
7/12/15 12:00 == 44.6	7/12/15 16:35 == 44.5	7/12/15 21:10 == 44.5	7/13/15 1:45 == 32
7/12/15 12:05 == 44.6	7/12/15 16:40 == 44.3	7/12/15 21:15 == 44.5	7/13/15 1:50 == 32
7/12/15 12:10 == 44.6	7/12/15 16:45 == 44.5	7/12/15 21:20 == 44.5	7/13/15 1:55 == 31.8
7/12/15 12:15 == 44.8	7/12/15 16:50 == 44.5	7/12/15 21:25 == 44.3	7/13/15 2:00 == 44
7/12/15 12:20 == 44.5	7/12/15 16:55 == 44.3	7/12/15 21:30 == 44.3	7/13/15 2:05 == 44.5
7/12/15 12:25 == 44.6	7/12/15 17:00 == 44.4	7/12/15 21:35 == 44.3	7/13/15 2:10 == 44.4
7/12/15 12:30 == 44.5	7/12/15 17:05 == 44.4	7/12/15 21:40 == 44.4	7/13/15 2:15 == 44.4
7/12/15 12:35 == 44.6	7/12/15 17:10 == 44.3	7/12/15 21:45 == 44.2	7/13/15 2:20 == 44.4
7/12/15 12:40 == 44.6	7/12/15 17:15 == 44.4	7/12/15 21:50 == 44.3	7/13/15 2:25 == 44.4
7/12/15 12:45 == 44.6	7/12/15 17:20 == 44.5	7/12/15 21:55 == 40.5	7/13/15 2:30 == 44.5
7/12/15 12:50 == 44.6	7/12/15 17:25 == 44.6	7/12/15 22:00 == 31	7/13/15 2:35 == 44.3
7/12/15 12:55 == 44.4	7/12/15 17:30 == 44.7	7/12/15 22:05 == 30.9	7/13/15 2:40 == 44.4
7/12/15 13:00 == 44.5	7/12/15 17:35 == 44.6	7/12/15 22:10 == 31.2	7/13/15 2:45 == 44.4
7/12/15 13:05 == 44.4	7/12/15 17:40 == 44.9	7/12/15 22:15 == 31.4	7/13/15 2:50 == 44.4
7/12/15 13:10 == 44.5	7/12/15 17:45 == 44.6	7/12/15 22:20 == 31.7	7/13/15 2:55 == 44.3
7/12/15 13:15 == 44.4	7/12/15 17:50 == 44.6	7/12/15 22:25 == 31.8	7/13/15 3:00 == 44.3
7/12/15 13:20 == 44.5	7/12/15 17:55 == 44.6	7/12/15 22:30 == 32.1	7/13/15 3:05 == 44.5
7/12/15 13:25 == 44.7	7/12/15 18:00 == 44.7	7/12/15 22:35 == 32.1	7/13/15 3:10 == 44.3
7/12/15 13:30 == 44.8	7/12/15 18:05 == 44.6	7/12/15 22:40 == 32.1	7/13/15 3:15 == 44.2
7/12/15 13:35 == 44.9	7/12/15 18:10 == 45.2	7/12/15 22:45 == 32.3	7/13/15 3:20 == 44.3
7/12/15 13:40 == 45.1	7/12/15 18:15 == 45.1	7/12/15 22:50 == 32.3	7/13/15 3:25 == 39.9
7/12/15 13:45 == 44.9	7/12/15 18:20 == 45	7/12/15 22:55 == 31.9	7/13/15 3:30 == 31
7/12/15 13:50 == 45	7/12/15 18:25 == 45.2	7/12/15 23:00 == 44.1	7/13/15 3:35 == 31
7/12/15 13:55 == 45.2	7/12/15 18:30 == 45.1	7/12/15 23:05 == 45.2	7/13/15 3:40 == 31.2
7/12/15 14:00 == 45.2	7/12/15 18:35 == 45	7/12/15 23:10 == 45.1	7/13/15 3:45 == 31.4
7/12/15 14:05 == 45.5	7/12/15 18:40 == 45.1	7/12/15 23:15 == 44.9	7/13/15 3:50 == 31.4
7/12/15 14:10 == 45.2	7/12/15 18:45 == 45	7/12/15 23:20 == 45.1	7/13/15 3:55 == 31.6
7/12/15 14:15 == 45.5	7/12/15 18:50 == 45.1	7/12/15 23:25 == 45.2	7/13/15 4:00 == 31.9
7/12/15 14:20 == 45.3	7/12/15 18:55 == 45.1	7/12/15 23:30 == 45.1	7/13/15 4:05 == 31.9
7/12/15 14:25 == 45.3	7/12/15 19:00 == 45	7/12/15 23:35 == 45	7/13/15 4:10 == 32
7/12/15 14:30 == 45.3	7/12/15 19:05 == 45.1	7/12/15 23:40 == 45.2	7/13/15 4:15 == 32.2
7/12/15 14:35 == 45	7/12/15 19:10 == 44.6	7/12/15 23:45 == 45.1	7/13/15 4:20 == 32.3
7/12/15 14:40 == 45	7/12/15 19:15 == 44.6	7/12/15 23:50 == 44.9	7/13/15 4:25 == 32.3
7/12/15 14:45 == 45	7/12/15 19:20 == 44.6	7/12/15 23:55 == 44.9	7/13/15 4:30 == 44.5
7/12/15 14:50 == 45.1	7/12/15 19:25 == 44.6	7/13/15 0:00 == 44.8	7/13/15 4:35 == 44.8
7/12/15 14:55 == 44.7	7/12/15 19:30 == 44.6	7/13/15 0:05 == 44.4	7/13/15 4:40 == 44.7
7/12/15 15:00 == 44.5	7/12/15 19:35 == 44.5	7/13/15 0:10 == 44.4	7/13/15 4:45 == 44.7
7/12/15 15:05 == 44.5	7/12/15 19:40 == 44.8	7/13/15 0:15 == 44.3	7/13/15 4:50 == 44.6
7/12/15 15:10 == 44.5	7/12/15 19:45 == 44.4	7/13/15 0:20 == 44.3	7/13/15 4:55 == 44.7
7/12/15 15:15 == 44.4	7/12/15 19:50 == 44.6	7/13/15 0:25 == 44.4	7/13/15 5:00 == 44.9
7/12/15 15:20 == 44.4	7/12/15 19:55 == 44.5	7/13/15 0:30 == 44.5	7/13/15 5:05 == 45
7/12/15 15:25 == 44.5	7/12/15 20:00 == 44.6	7/13/15 0:35 == 44.4	7/13/15 5:10 == 44.9
7/12/15 15:30 == 44.5	7/12/15 20:05 == 44.6	7/13/15 0:40 == 44.3	7/13/15 5:15 == 44.4

Pumpback Station Discharge (0364)

7/13/15 5:20 == 44.6	7/13/15 9:55 == 46.3	7/13/15 14:30 == 46.1	7/13/15 19:05 == 45.9
7/13/15 5:25 == 44.8	7/13/15 10:00 == 46.5	7/13/15 14:35 == 46.7	7/13/15 19:10 == 46
7/13/15 5:30 == 44.6	7/13/15 10:05 == 46.5	7/13/15 14:40 == 46.8	7/13/15 19:15 == 45.6
7/13/15 5:35 == 44.6	7/13/15 10:10 == 46.3	7/13/15 14:45 == 46.8	7/13/15 19:20 == 45.9
7/13/15 5:40 == 44.8	7/13/15 10:15 == 46.5	7/13/15 14:50 == 46.5	7/13/15 19:25 == 45.8
7/13/15 5:45 == 44.7	7/13/15 10:20 == 46.2	7/13/15 14:55 == 41.1	7/13/15 19:30 == 45.7
7/13/15 5:50 == 44.9	7/13/15 10:25 == 46.5	7/13/15 15:00 == #	7/13/15 19:35 == 45.6
7/13/15 5:55 == 39.9	7/13/15 10:30 == 46.3	7/13/15 15:05 == 31.6	7/13/15 19:40 == 45.6
7/13/15 6:00 == 30.8	7/13/15 10:35 == 45.8	7/13/15 15:10 == 32.3	7/13/15 19:45 == 45.7
7/13/15 6:05 == 31.1	7/13/15 10:40 == 46.7	7/13/15 15:15 == 31.6	7/13/15 19:50 == 45.8
7/13/15 6:10 == 31.3	7/13/15 10:45 == 46.4	7/13/15 15:20 == 32.1	7/13/15 19:55 == 45.6
7/13/15 6:15 == 31.4	7/13/15 10:50 == 46.3	7/13/15 15:25 == 32.1	7/13/15 20:00 == 45.9
7/13/15 6:20 == 31.6	7/13/15 10:55 == 46.5	7/13/15 15:30 == 32.3	7/13/15 20:05 == 45.4
7/13/15 6:25 == 31.5	7/13/15 11:00 == 46.5	7/13/15 15:35 == 32.8	7/13/15 20:10 == 45.6
7/13/15 6:30 == 32	7/13/15 11:05 == 46.7	7/13/15 15:40 == 32.7	7/13/15 20:15 == 40
7/13/15 6:35 == 31.8	7/13/15 11:10 == 46.8	7/13/15 15:45 == 32.7	7/13/15 20:20 == 31.3
7/13/15 6:40 == 32	7/13/15 11:15 == 46.3	7/13/15 15:50 == 32.8	7/13/15 20:25 == 31.6
7/13/15 6:45 == 32.3	7/13/15 11:20 == 46.9	7/13/15 15:55 == 32.8	7/13/15 20:30 == 31.6
7/13/15 6:50 == 31.8	7/13/15 11:25 == 46.3	7/13/15 16:00 == 33.3	7/13/15 20:35 == 32
7/13/15 6:55 == 31.6	7/13/15 11:30 == 46.3	7/13/15 16:05 == 46.2	7/13/15 20:40 == 32
7/13/15 7:00 == 31.8	7/13/15 11:35 == 46.5	7/13/15 16:10 == 46.3	7/13/15 20:45 == 32.2
7/13/15 7:05 == 32.2	7/13/15 11:40 == 41.2	7/13/15 16:15 == 46.1	7/13/15 20:50 == 32.4
7/13/15 7:10 == 32.4	7/13/15 11:45 == 31.7	7/13/15 16:20 == 46.1	7/13/15 20:55 == 32.5
7/13/15 7:15 == 32	7/13/15 11:50 == 31.8	7/13/15 16:25 == 46.2	7/13/15 21:00 == 32.4
7/13/15 7:20 == 32.6	7/13/15 11:55 == 32.1	7/13/15 16:30 == 45.8	7/13/15 21:05 == 32.6
7/13/15 7:25 == 32.6	7/13/15 12:00 == 32.5	7/13/15 16:35 == 46	7/13/15 21:10 == 32.7
7/13/15 7:30 == 32.4	7/13/15 12:05 == 32.5	7/13/15 16:40 == 45.8	7/13/15 21:15 == 33.4
7/13/15 7:35 == 32.6	7/13/15 12:10 == 32.5	7/13/15 16:45 == 45.9	7/13/15 21:20 == 45.9
7/13/15 7:40 == 32.4	7/13/15 12:15 == 33.2	7/13/15 16:50 == 45.9	7/13/15 21:25 == 46
7/13/15 7:45 == 32.7	7/13/15 12:20 == 32.8	7/13/15 16:55 == 46	7/13/15 21:30 == 45.9
7/13/15 7:50 == 32.6	7/13/15 12:25 == 32.9	7/13/15 17:00 == 45.9	7/13/15 21:35 == 45.9
7/13/15 7:55 == 32.7	7/13/15 12:30 == 46.5	7/13/15 17:05 == 45.9	7/13/15 21:40 == 45.9
7/13/15 8:00 == 32.6	7/13/15 12:35 == 46.7	7/13/15 17:10 == 45.9	7/13/15 21:45 == 45.8
7/13/15 8:05 == 32.9	7/13/15 12:40 == 47	7/13/15 17:15 == 40.5	7/13/15 21:50 == 46
7/13/15 8:10 == 32.8	7/13/15 12:45 == 46.3	7/13/15 17:20 == 31.4	7/13/15 21:55 == 45.9
7/13/15 8:15 == 32.8	7/13/15 12:50 == 46.2	7/13/15 17:25 == 31.6	7/13/15 22:00 == 45.9
7/13/15 8:20 == 32.7	7/13/15 12:55 == 46.9	7/13/15 17:30 == 31.7	7/13/15 22:05 == 45.7
7/13/15 8:25 == 32.6	7/13/15 13:00 == 46.8	7/13/15 17:35 == 32.1	7/13/15 22:10 == 45.8
7/13/15 8:30 == 32.7	7/13/15 13:05 == 46.8	7/13/15 17:40 == 32.2	7/13/15 22:15 == 45.8
7/13/15 8:35 == 32.8	7/13/15 13:10 == 46.4	7/13/15 17:45 == 32.3	7/13/15 22:20 == 45.9
7/13/15 8:40 == 32.9	7/13/15 13:15 == 46.9	7/13/15 17:50 == 32.5	7/13/15 22:25 == 46.1
7/13/15 8:45 == 33	7/13/15 13:20 == 46.7	7/13/15 17:55 == 32.4	7/13/15 22:30 == 46
7/13/15 8:50 == 32.9	7/13/15 13:25 == 46.3	7/13/15 18:00 == 32.5	7/13/15 22:35 == 46.1
7/13/15 8:55 == 32.8	7/13/15 13:30 == 46.7	7/13/15 18:05 == 32.6	7/13/15 22:40 == 45.9
7/13/15 9:00 == 33	7/13/15 13:35 == 46.9	7/13/15 18:10 == 32.8	7/13/15 22:45 == 40.2
7/13/15 9:05 == 33	7/13/15 13:40 == 46.1	7/13/15 18:15 == 32.7	7/13/15 22:50 == 31.6
7/13/15 9:10 == 32.8	7/13/15 13:45 == 46.8	7/13/15 18:20 == 45.8	7/13/15 22:55 == 31.7
7/13/15 9:15 == 33	7/13/15 13:50 == 46.7	7/13/15 18:25 == 46.1	7/13/15 23:00 == 31.8
7/13/15 9:20 == 32.9	7/13/15 13:55 == 46.4	7/13/15 18:30 == 46	7/13/15 23:05 == 32.2
7/13/15 9:25 == 32.8	7/13/15 14:00 == #	7/13/15 18:35 == 46.1	7/13/15 23:10 == 32.2
7/13/15 9:30 == 46.2	7/13/15 14:05 == 46.7	7/13/15 18:40 == 45.9	7/13/15 23:15 == 32.4
7/13/15 9:35 == 46.3	7/13/15 14:10 == 46.7	7/13/15 18:45 == 45.9	7/13/15 23:20 == 32.2
7/13/15 9:40 == 46.5	7/13/15 14:15 == 46.6	7/13/15 18:50 == 46	7/13/15 23:25 == 32.4
7/13/15 9:45 == 46.3	7/13/15 14:20 == 46.9	7/13/15 18:55 == 46	7/13/15 23:30 == 32.4
7/13/15 9:50 == 46.5	7/13/15 14:25 == 46.9	7/13/15 19:00 == 45.9	7/13/15 23:35 == 32.7

Pumpback Station Discharge (0364)

7/13/15 23:40 == 32.6	7/14/15 4:15 == 38.6	7/14/15 8:50 == 33.2	7/14/15 13:25 == 32.7
7/13/15 23:45 == 33.5	7/14/15 4:20 == 30.9	7/14/15 8:55 == 33	7/14/15 13:30 == 29.9
7/13/15 23:50 == 45.9	7/14/15 4:25 == 31.1	7/14/15 9:00 == 33.1	7/14/15 13:35 == 27.1
7/13/15 23:55 == 46.1	7/14/15 4:30 == 31.2	7/14/15 9:05 == 33.3	7/14/15 13:40 == 26.5
7/14/15 0:00 == 46	7/14/15 4:35 == 31.4	7/14/15 9:10 == 33.1	7/14/15 13:45 == 26.7
7/14/15 0:05 == 45.8	7/14/15 4:40 == 31.5	7/14/15 9:15 == 33.2	7/14/15 13:50 == 27
7/14/15 0:10 == 45.9	7/14/15 4:45 == 31.6	7/14/15 9:20 == 33.1	7/14/15 13:55 == 26.7
7/14/15 0:15 == 45.9	7/14/15 4:50 == 31.8	7/14/15 9:25 == 33.2	7/14/15 14:00 == 26.7
7/14/15 0:20 == 45.9	7/14/15 4:55 == 32	7/14/15 9:30 == 32.7	7/14/15 14:05 == 33.4
7/14/15 0:25 == 45.8	7/14/15 5:00 == 32.1	7/14/15 9:35 == 33	7/14/15 14:10 == 46.6
7/14/15 0:30 == 45.9	7/14/15 5:05 == 32.2	7/14/15 9:40 == 33.2	7/14/15 14:15 == 46.6
7/14/15 0:35 == 46	7/14/15 5:10 == 32.2	7/14/15 9:45 == 33.8	7/14/15 14:20 == 46.8
7/14/15 0:40 == 45.8	7/14/15 5:15 == 33.3	7/14/15 9:50 == 46.8	7/14/15 14:25 == 46.2
7/14/15 0:45 == 45.8	7/14/15 5:20 == 44.9	7/14/15 9:55 == 46.4	7/14/15 14:30 == 46.8
7/14/15 0:50 == 45.9	7/14/15 5:25 == 44.9	7/14/15 10:00 == 46.5	7/14/15 14:35 == 46.1
7/14/15 0:55 == 45.8	7/14/15 5:30 == 44.8	7/14/15 10:05 == 46.6	7/14/15 14:40 == 46.4
7/14/15 1:00 == 45.9	7/14/15 5:35 == 44.7	7/14/15 10:10 == 47	7/14/15 14:45 == 46.4
7/14/15 1:05 == 45.9	7/14/15 5:40 == 44.8	7/14/15 10:15 == 46.4	7/14/15 14:50 == 47
7/14/15 1:10 == 45.9	7/14/15 5:45 == 44.9	7/14/15 10:20 == 46.2	7/14/15 14:55 == 45.9
7/14/15 1:15 == 39.6	7/14/15 5:50 == 44.7	7/14/15 10:25 == 46.6	7/14/15 15:00 == 46.5
7/14/15 1:20 == 31.4	7/14/15 5:55 == 44.9	7/14/15 10:30 == 46.5	7/14/15 15:05 == 46
7/14/15 1:25 == 31.5	7/14/15 6:00 == 44.6	7/14/15 10:35 == 46.7	7/14/15 15:10 == 46.4
7/14/15 1:30 == 31.7	7/14/15 6:05 == 44.5	7/14/15 10:40 == 46.6	7/14/15 15:15 == 46.8
7/14/15 1:35 == 32.1	7/14/15 6:10 == 45	7/14/15 10:45 == 46.7	7/14/15 15:20 == 46.3
7/14/15 1:40 == 31.9	7/14/15 6:15 == 44.8	7/14/15 10:50 == 46.7	7/14/15 15:25 == 46.7
7/14/15 1:45 == 32.1	7/14/15 6:20 == 45	7/14/15 10:55 == 47	7/14/15 15:30 == 46.4
7/14/15 1:50 == 32.3	7/14/15 6:25 == 45.1	7/14/15 11:00 == 46.3	7/14/15 15:35 == 47.2
7/14/15 1:55 == 32.3	7/14/15 6:30 == 38.8	7/14/15 11:05 == 46.7	7/14/15 15:40 == 46.5
7/14/15 2:00 == 32.4	7/14/15 6:35 == 31.7	7/14/15 11:10 == 46.7	7/14/15 15:45 == 46.1
7/14/15 2:05 == 32.5	7/14/15 6:40 == 31.2	7/14/15 11:15 == 46.6	7/14/15 15:50 == 46.4
7/14/15 2:10 == 32.5	7/14/15 6:45 == 31.6	7/14/15 11:20 == 46.9	7/14/15 15:55 == 46.8
7/14/15 2:15 == 32.6	7/14/15 6:50 == 32	7/14/15 11:25 == 46.6	7/14/15 16:00 == 46
7/14/15 2:20 == 32.8	7/14/15 6:55 == 32	7/14/15 11:30 == 46.1	7/14/15 16:05 == 46.5
7/14/15 2:25 == 32.7	7/14/15 7:00 == 32.4	7/14/15 11:35 == 46.6	7/14/15 16:10 == 45.8
7/14/15 2:30 == 33.6	7/14/15 7:05 == 32	7/14/15 11:40 == 46.5	7/14/15 16:15 == 46.2
7/14/15 2:35 == 45.8	7/14/15 7:10 == 32	7/14/15 11:45 == 46.6	7/14/15 16:20 == 45.8
7/14/15 2:40 == 45.9	7/14/15 7:15 == 32.1	7/14/15 11:50 == 46.8	7/14/15 16:25 == 46
7/14/15 2:45 == 45.8	7/14/15 7:20 == 32.2	7/14/15 11:55 == 46.6	7/14/15 16:30 == 45.6
7/14/15 2:50 == 45.8	7/14/15 7:25 == 32.1	7/14/15 12:00 == 46.8	7/14/15 16:35 == 45.8
7/14/15 2:55 == 45.8	7/14/15 7:30 == 32.2	7/14/15 12:05 == 46.6	7/14/15 16:40 == 45.9
7/14/15 3:00 == 45.8	7/14/15 7:35 == 31.9	7/14/15 12:10 == 46.8	7/14/15 16:45 == 45.8
7/14/15 3:05 == 45.7	7/14/15 7:40 == 32.2	7/14/15 12:15 == 46.3	7/14/15 16:50 == 45.7
7/14/15 3:10 == 45.5	7/14/15 7:45 == 32.1	7/14/15 12:20 == 46.4	7/14/15 16:55 == 45.6
7/14/15 3:15 == 45.2	7/14/15 7:50 == 32.6	7/14/15 12:25 == 46.3	7/14/15 17:00 == 39
7/14/15 3:20 == 44.8	7/14/15 7:55 == 32.4	7/14/15 12:30 == 46.4	7/14/15 17:05 == 31.5
7/14/15 3:25 == 45	7/14/15 8:00 == 32.5	7/14/15 12:35 == 46.4	7/14/15 17:10 == 31.5
7/14/15 3:30 == 44.7	7/14/15 8:05 == 32.5	7/14/15 12:40 == 46.3	7/14/15 17:15 == 31.8
7/14/15 3:35 == 44.7	7/14/15 8:10 == 32.6	7/14/15 12:45 == 39.7	7/14/15 17:20 == 31.7
7/14/15 3:40 == 44.8	7/14/15 8:15 == 32.7	7/14/15 12:50 == 31.7	7/14/15 17:25 == 31.8
7/14/15 3:45 == 44.6	7/14/15 8:20 == 32.7	7/14/15 12:55 == 31.3	7/14/15 17:30 == 32
7/14/15 3:50 == 44.6	7/14/15 8:25 == 32.7	7/14/15 13:00 == 32.2	7/14/15 17:35 == 32.3
7/14/15 3:55 == 44.7	7/14/15 8:30 == 32.7	7/14/15 13:05 == 32.9	7/14/15 17:40 == 32.2
7/14/15 4:00 == 45	7/14/15 8:35 == 32.6	7/14/15 13:10 == 32.6	7/14/15 17:45 == 32.4
7/14/15 4:05 == 44.7	7/14/15 8:40 == 32.8	7/14/15 13:15 == 32.7	7/14/15 17:50 == 32.6
7/14/15 4:10 == 44.9	7/14/15 8:45 == 32.8	7/14/15 13:20 == 32.7	7/14/15 17:55 == 32.6

Pumpback Station Discharge (0364)

7/14/15 18:00 == 34.2	7/14/15 22:35 == 32.5	7/15/15 3:10 == 32.9	7/15/15 7:45 == 46.7
7/14/15 18:05 == 45.7	7/14/15 22:40 == 32.4	7/15/15 3:15 == 32.9	7/15/15 7:50 == 46.8
7/14/15 18:10 == 45.9	7/14/15 22:45 == 32.7	7/15/15 3:20 == 32.8	7/15/15 7:55 == 47.1
7/14/15 18:15 == 46	7/14/15 22:50 == 32.7	7/15/15 3:25 == 32.9	7/15/15 8:00 == 47
7/14/15 18:20 == 45.9	7/14/15 22:55 == 32.6	7/15/15 3:30 == 32.9	7/15/15 8:05 == 47.1
7/14/15 18:25 == 45.8	7/14/15 23:00 == 34.9	7/15/15 3:35 == 32.9	7/15/15 8:10 == 47.5
7/14/15 18:30 == 45.9	7/14/15 23:05 == 45.7	7/15/15 3:40 == 32.9	7/15/15 8:15 == 46.3
7/14/15 18:35 == 45.9	7/14/15 23:10 == 46	7/15/15 3:45 == 32.8	7/15/15 8:20 == 46.7
7/14/15 18:40 == 45.8	7/14/15 23:15 == 46.1	7/15/15 3:50 == 32.9	7/15/15 8:25 == 46.8
7/14/15 18:45 == 45.9	7/14/15 23:20 == 45.9	7/15/15 3:55 == 33	7/15/15 8:30 == 47
7/14/15 18:50 == 46.1	7/14/15 23:25 == 45.9	7/15/15 4:00 == 33	7/15/15 8:35 == 46.9
7/14/15 18:55 == 45.8	7/14/15 23:30 == 46.1	7/15/15 4:05 == 32.9	7/15/15 8:40 == 47
7/14/15 19:00 == 45.8	7/14/15 23:35 == 45.9	7/15/15 4:10 == 32.9	7/15/15 8:45 == 47
7/14/15 19:05 == 45.8	7/14/15 23:40 == 46	7/15/15 4:15 == 39.2	7/15/15 8:50 == 47.2
7/14/15 19:10 == 46	7/14/15 23:45 == 45.8	7/15/15 4:20 == 45.9	7/15/15 8:55 == 46.8
7/14/15 19:15 == 45.5	7/14/15 23:50 == 45.8	7/15/15 4:25 == 45.9	7/15/15 9:00 == 47.2
7/14/15 19:20 == 45.5	7/14/15 23:55 == 45.8	7/15/15 4:30 == 46.1	7/15/15 9:05 == 46.6
7/14/15 19:25 == 45.5	7/15/15 0:00 == 45.7	7/15/15 4:35 == 46	7/15/15 9:10 == 46.8
7/14/15 19:30 == 38.4	7/15/15 0:05 == 45.4	7/15/15 4:40 == 46	7/15/15 9:15 == 46.6
7/14/15 19:35 == 31.5	7/15/15 0:10 == 1.9	7/15/15 4:45 == 45.9	7/15/15 9:20 == 46.6
7/14/15 19:40 == 31.4	7/15/15 0:15 == 0	7/15/15 4:50 == 46.1	7/15/15 9:25 == 46.9
7/14/15 19:45 == 31.7	7/15/15 0:20 == 0	7/15/15 4:55 == 45.9	7/15/15 9:30 == 46.8
7/14/15 19:50 == 31.9	7/15/15 0:25 == 0	7/15/15 5:00 == 46	7/15/15 9:35 == 47
7/14/15 19:55 == 31.8	7/15/15 0:30 == 0	7/15/15 5:05 == 46	7/15/15 9:40 == 46.3
7/14/15 20:00 == 32.1	7/15/15 0:35 == 0	7/15/15 5:10 == 46.3	7/15/15 9:45 == 38.2
7/14/15 20:05 == 32.3	7/15/15 0:40 == #	7/15/15 5:15 == 46.6	7/15/15 9:50 == 31.7
7/14/15 20:10 == 32.2	7/15/15 0:45 == 0	7/15/15 5:20 == 45.9	7/15/15 9:55 == 32
7/14/15 20:15 == 32.5	7/15/15 0:50 == 0	7/15/15 5:25 == 45.9	7/15/15 10:00 == 32
7/14/15 20:20 == 32.4	7/15/15 0:55 == 0	7/15/15 5:30 == 46	7/15/15 10:05 == 32.4
7/14/15 20:25 == 32.6	7/15/15 1:00 == 0	7/15/15 5:35 == 46.3	7/15/15 10:10 == 32.2
7/14/15 20:30 == 34.2	7/15/15 1:05 == 14.2	7/15/15 5:40 == 46	7/15/15 10:15 == 32.7
7/14/15 20:35 == 45.8	7/15/15 1:10 == 33.2	7/15/15 5:45 == 45.9	7/15/15 10:20 == 32.5
7/14/15 20:40 == 45.8	7/15/15 1:15 == 33	7/15/15 5:50 == 45.8	7/15/15 10:25 == 32.6
7/14/15 20:45 == 45.9	7/15/15 1:20 == 32.8	7/15/15 5:55 == 45.8	7/15/15 10:30 == 32.9
7/14/15 20:50 == 45.9	7/15/15 1:25 == 32.9	7/15/15 6:00 == 46.3	7/15/15 10:35 == 33.1
7/14/15 20:55 == 45.7	7/15/15 1:30 == 33	7/15/15 6:05 == 45.8	7/15/15 10:40 == 32.8
7/14/15 21:00 == 45.8	7/15/15 1:35 == 33	7/15/15 6:10 == 45.9	7/15/15 10:45 == 33
7/14/15 21:05 == 45.8	7/15/15 1:40 == 32.9	7/15/15 6:15 == 45.9	7/15/15 10:50 == 32.9
7/14/15 21:10 == 46	7/15/15 1:45 == 32.8	7/15/15 6:20 == 45.8	7/15/15 10:55 == 33.5
7/14/15 21:15 == 45.9	7/15/15 1:50 == 32.9	7/15/15 6:25 == 45.9	7/15/15 11:00 == 35.4
7/14/15 21:20 == 45.9	7/15/15 1:55 == 32.8	7/15/15 6:30 == 46	7/15/15 11:05 == 47.3
7/14/15 21:25 == 45.8	7/15/15 2:00 == 32.9	7/15/15 6:35 == 46.4	7/15/15 11:10 == 46.7
7/14/15 21:30 == 45.7	7/15/15 2:05 == 33	7/15/15 6:40 == 46.1	7/15/15 11:15 == 47.1
7/14/15 21:35 == 45.8	7/15/15 2:10 == 32.9	7/15/15 6:45 == 46.6	7/15/15 11:20 == 47
7/14/15 21:40 == 45.9	7/15/15 2:15 == 33	7/15/15 6:50 == 45.9	7/15/15 11:25 == 46.4
7/14/15 21:45 == 45.7	7/15/15 2:20 == 32.8	7/15/15 6:55 == 46	7/15/15 11:30 == 47.1
7/14/15 21:50 == 45.7	7/15/15 2:25 == 32.9	7/15/15 7:00 == 46	7/15/15 11:35 == 46.6
7/14/15 21:55 == 45.7	7/15/15 2:30 == 32.9	7/15/15 7:05 == 46.4	7/15/15 11:40 == 47
7/14/15 22:00 == 38.3	7/15/15 2:35 == 33	7/15/15 7:10 == 46.8	7/15/15 11:45 == 46.7
7/14/15 22:05 == 31.5	7/15/15 2:40 == 32.8	7/15/15 7:15 == 46.5	7/15/15 11:50 == 46.9
7/14/15 22:10 == 31.5	7/15/15 2:45 == 32.9	7/15/15 7:20 == 46.3	7/15/15 11:55 == 47
7/14/15 22:15 == 31.9	7/15/15 2:50 == 32.9	7/15/15 7:25 == 46.7	7/15/15 12:00 == 47
7/14/15 22:20 == 32	7/15/15 2:55 == 32.8	7/15/15 7:30 == 47.2	7/15/15 12:05 == 47.3
7/14/15 22:25 == 32	7/15/15 3:00 == 33	7/15/15 7:35 == 46.9	7/15/15 12:10 == 47.1
7/14/15 22:30 == 32.3	7/15/15 3:05 == 32.9	7/15/15 7:40 == 47	7/15/15 12:15 == 46.9

Pumpback Station Discharge (0364)

7/15/15 12:20 == 47	7/15/15 16:55 == 32.6	7/15/15 21:30 == 45.7	7/16/15 2:05 == 45.6
7/15/15 12:25 == 47	7/15/15 17:00 == 32.6	7/15/15 21:35 == 45.7	7/16/15 2:10 == 45.6
7/15/15 12:30 == 47.2	7/15/15 17:05 == 32.8	7/15/15 21:40 == 45.6	7/16/15 2:15 == 45.7
7/15/15 12:35 == 46.8	7/15/15 17:10 == 32.6	7/15/15 21:45 == 36.4	7/16/15 2:20 == 45.6
7/15/15 12:40 == 47.2	7/15/15 17:15 == 32.9	7/15/15 21:50 == 31.4	7/16/15 2:25 == 45.6
7/15/15 12:45 == 47	7/15/15 17:20 == 32.7	7/15/15 21:55 == 31.6	7/16/15 2:30 == 36.3
7/15/15 12:50 == 46.9	7/15/15 17:25 == 32.8	7/15/15 22:00 == 31.8	7/16/15 2:35 == 31.4
7/15/15 12:55 == 47.1	7/15/15 17:30 == 35.1	7/15/15 22:05 == 31.9	7/16/15 2:40 == 31.6
7/15/15 13:00 == 46.8	7/15/15 17:35 == 45.9	7/15/15 22:10 == 32	7/16/15 2:45 == 31.8
7/15/15 13:05 == 47.1	7/15/15 17:40 == 45.8	7/15/15 22:15 == 32.1	7/16/15 2:50 == 31.9
7/15/15 13:10 == 47	7/15/15 17:45 == 45.6	7/15/15 22:20 == 32.3	7/16/15 2:55 == 31.9
7/15/15 13:15 == 47.3	7/15/15 17:50 == 45.7	7/15/15 22:25 == 32.1	7/16/15 3:00 == 32
7/15/15 13:20 == 46.7	7/15/15 17:55 == 45.8	7/15/15 22:30 == 32.5	7/16/15 3:05 == 32.2
7/15/15 13:25 == 46.5	7/15/15 18:00 == 45.7	7/15/15 22:35 == 32.5	7/16/15 3:10 == 32.3
7/15/15 13:30 == 46.9	7/15/15 18:05 == 45.6	7/15/15 22:40 == 32.6	7/16/15 3:15 == 32.4
7/15/15 13:35 == 47.1	7/15/15 18:10 == 45.7	7/15/15 22:45 == 32.6	7/16/15 3:20 == 32.3
7/15/15 13:40 == 46.9	7/15/15 18:15 == 45.7	7/15/15 22:50 == 32.5	7/16/15 3:25 == 32.4
7/15/15 13:45 == 46.9	7/15/15 18:20 == 45.7	7/15/15 22:55 == 32.6	7/16/15 3:30 == 32.4
7/15/15 13:50 == 47.1	7/15/15 18:25 == 45.6	7/15/15 23:00 == 35.6	7/16/15 3:35 == 32.4
7/15/15 13:55 == 47	7/15/15 18:30 == 45.7	7/15/15 23:05 == 45.8	7/16/15 3:40 == 32.4
7/15/15 14:00 == 38	7/15/15 18:35 == 45.4	7/15/15 23:10 == 45.8	7/16/15 3:45 == 32.7
7/15/15 14:05 == 32.1	7/15/15 18:40 == 45.6	7/15/15 23:15 == 46	7/16/15 3:50 == 32.6
7/15/15 14:10 == 31.9	7/15/15 18:45 == 37	7/15/15 23:20 == 45.8	7/16/15 3:55 == 32.7
7/15/15 14:15 == 32.3	7/15/15 18:50 == 31.6	7/15/15 23:25 == 45.8	7/16/15 4:00 == 32.6
7/15/15 14:20 == 32.6	7/15/15 18:55 == 31.6	7/15/15 23:30 == 45.9	7/16/15 4:05 == 32.7
7/15/15 14:25 == 32.5	7/15/15 19:00 == 31.8	7/15/15 23:35 == 45.8	7/16/15 4:10 == 32.8
7/15/15 14:30 == 32.9	7/15/15 19:05 == 32	7/15/15 23:40 == 45.7	7/16/15 4:15 == 28.7
7/15/15 14:35 == 33.2	7/15/15 19:10 == 32	7/15/15 23:45 == 45.6	7/16/15 4:20 == 26.7
7/15/15 14:40 == 32.8	7/15/15 19:15 == 32.3	7/15/15 23:50 == 45.7	7/16/15 4:25 == 26.8
7/15/15 14:45 == 33	7/15/15 19:20 == 32.1	7/15/15 23:55 == 45.7	7/16/15 4:30 == 26.8
7/15/15 14:50 == 32.7	7/15/15 19:25 == 32.4	7/16/15 0:00 == 36.5	7/16/15 4:35 == 26.6
7/15/15 14:55 == 33.3	7/15/15 19:30 == 32.5	7/16/15 0:05 == 31.6	7/16/15 4:40 == 26.7
7/15/15 15:00 == 35.2	7/15/15 19:35 == 32.6	7/16/15 0:10 == 31.7	7/16/15 4:45 == 27.3
7/15/15 15:05 == 47.1	7/15/15 19:40 == 32.7	7/16/15 0:15 == 31.8	7/16/15 4:50 == 44.2
7/15/15 15:10 == 47.4	7/15/15 19:45 == 32.8	7/16/15 0:20 == 32.1	7/16/15 4:55 == 45.8
7/15/15 15:15 == 46.9	7/15/15 19:50 == 32.7	7/16/15 0:25 == 32	7/16/15 5:00 == 45.7
7/15/15 15:20 == 46.7	7/15/15 19:55 == 32.9	7/16/15 0:30 == 32.3	7/16/15 5:05 == 45.7
7/15/15 15:25 == 46.9	7/15/15 20:00 == 35.5	7/16/15 0:35 == 32.3	7/16/15 5:10 == 45.6
7/15/15 15:30 == 46.9	7/15/15 20:05 == 45.8	7/16/15 0:40 == 32.4	7/16/15 5:15 == 45.3
7/15/15 15:35 == 46.9	7/15/15 20:10 == 45.8	7/16/15 0:45 == 32.5	7/16/15 5:20 == 44.6
7/15/15 15:40 == 47.1	7/15/15 20:15 == 45.7	7/16/15 0:50 == 32.6	7/16/15 5:25 == 44.5
7/15/15 15:45 == 47.1	7/15/15 20:20 == 45.8	7/16/15 0:55 == 32.5	7/16/15 5:30 == 45
7/15/15 15:50 == 46.4	7/15/15 20:25 == 45.7	7/16/15 1:00 == 32.6	7/16/15 5:35 == 44.9
7/15/15 15:55 == 46.4	7/15/15 20:30 == 45.8	7/16/15 1:05 == 32.8	7/16/15 5:40 == 44.5
7/15/15 16:00 == 46.6	7/15/15 20:35 == 45.6	7/16/15 1:10 == 32.8	7/16/15 5:45 == 44.5
7/15/15 16:05 == 46.3	7/15/15 20:40 == 45.8	7/16/15 1:15 == 36.2	7/16/15 5:50 == 44.4
7/15/15 16:10 == 46	7/15/15 20:45 == 45.7	7/16/15 1:20 == 45.7	7/16/15 5:55 == 44.6
7/15/15 16:15 == 37.5	7/15/15 20:50 == 45.6	7/16/15 1:25 == 45.8	7/16/15 6:00 == 45
7/15/15 16:20 == 31.7	7/15/15 20:55 == 45.6	7/16/15 1:30 == 45.6	7/16/15 6:05 == 45
7/15/15 16:25 == 31.7	7/15/15 21:00 == 45.6	7/16/15 1:35 == 45.7	7/16/15 6:10 == 44.3
7/15/15 16:30 == 32.1	7/15/15 21:05 == 45.7	7/16/15 1:40 == 45.7	7/16/15 6:15 == 44.4
7/15/15 16:35 == 32	7/15/15 21:10 == 45.8	7/16/15 1:45 == 45.6	7/16/15 6:20 == 45.3
7/15/15 16:40 == 32.2	7/15/15 21:15 == 45.9	7/16/15 1:50 == 45.7	7/16/15 6:25 == 45.4
7/15/15 16:45 == 32.3	7/15/15 21:20 == 45.5	7/16/15 1:55 == 45.6	7/16/15 6:30 == 36.2
7/15/15 16:50 == 32.3	7/15/15 21:25 == 45.8	7/16/15 2:00 == 45.5	7/16/15 6:35 == 31.8

Pumpback Station Discharge (0364)

7/16/15 6:40 == 31.7	7/16/15 11:15 == 47.1	7/16/15 15:50 == 46.6	7/16/15 20:25 == 31.6
7/16/15 6:45 == 32	7/16/15 11:20 == 47.2	7/16/15 15:55 == 47	7/16/15 20:30 == 31.9
7/16/15 6:50 == 32.2	7/16/15 11:25 == 47	7/16/15 16:00 == 46.9	7/16/15 20:35 == 32.1
7/16/15 6:55 == 32.2	7/16/15 11:30 == 47.1	7/16/15 16:05 == 46.9	7/16/15 20:40 == 32.1
7/16/15 7:00 == 32.1	7/16/15 11:35 == 47.1	7/16/15 16:10 == 47.1	7/16/15 20:45 == 32.4
7/16/15 7:05 == 32.1	7/16/15 11:40 == 46.8	7/16/15 16:15 == 46.4	7/16/15 20:50 == 32.3
7/16/15 7:10 == 32.3	7/16/15 11:45 == 47.1	7/16/15 16:20 == 46.7	7/16/15 20:55 == 32.4
7/16/15 7:15 == 32.2	7/16/15 11:50 == 47	7/16/15 16:25 == 45.4	7/16/15 21:00 == 32.4
7/16/15 7:20 == 32.2	7/16/15 11:55 == 46.9	7/16/15 16:30 == 35.6	7/16/15 21:05 == 32.8
7/16/15 7:25 == 31.9	7/16/15 12:00 == 47.1	7/16/15 16:35 == 31.7	7/16/15 21:10 == 32.8
7/16/15 7:30 == 32.1	7/16/15 12:05 == 46.9	7/16/15 16:40 == 31.6	7/16/15 21:15 == 32.7
7/16/15 7:35 == 32.2	7/16/15 12:10 == 47.2	7/16/15 16:45 == 32.2	7/16/15 21:20 == 32.7
7/16/15 7:40 == 31.9	7/16/15 12:15 == 36.9	7/16/15 16:50 == 32.1	7/16/15 21:25 == 32.7
7/16/15 7:45 == 32.1	7/16/15 12:20 == 32	7/16/15 16:55 == 32.3	7/16/15 21:30 == 37.2
7/16/15 7:50 == 32.2	7/16/15 12:25 == 32.2	7/16/15 17:00 == 32.2	7/16/15 21:35 == 46.2
7/16/15 7:55 == 32.4	7/16/15 12:30 == 32.2	7/16/15 17:05 == 32.3	7/16/15 21:40 == 46.2
7/16/15 8:00 == 32.4	7/16/15 12:35 == 32.8	7/16/15 17:10 == 32.5	7/16/15 21:45 == 46
7/16/15 8:05 == 32.6	7/16/15 12:40 == 32.8	7/16/15 17:15 == 32.6	7/16/15 21:50 == 46.1
7/16/15 8:10 == 32.4	7/16/15 12:45 == 33	7/16/15 17:20 == 32.7	7/16/15 21:55 == 46
7/16/15 8:15 == 32.6	7/16/15 12:50 == 32.8	7/16/15 17:25 == 32.7	7/16/15 22:00 == 46
7/16/15 8:20 == 32.7	7/16/15 12:55 == 33	7/16/15 17:30 == 32.6	7/16/15 22:05 == 46.1
7/16/15 8:25 == 32.7	7/16/15 13:00 == 33.1	7/16/15 17:35 == 32.6	7/16/15 22:10 == 46.1
7/16/15 8:30 == 32.8	7/16/15 13:05 == 33.2	7/16/15 17:40 == 32.7	7/16/15 22:15 == 46
7/16/15 8:35 == 32.6	7/16/15 13:10 == 33.1	7/16/15 17:45 == 28.6	7/16/15 22:20 == 46.1
7/16/15 8:40 == 32.9	7/16/15 13:15 == 37.4	7/16/15 17:50 == 26.6	7/16/15 22:25 == 46.1
7/16/15 8:45 == 32.7	7/16/15 13:20 == 47.3	7/16/15 17:55 == 26.7	7/16/15 22:30 == 45.9
7/16/15 8:50 == 33	7/16/15 13:25 == 47.2	7/16/15 18:00 == 26.6	7/16/15 22:35 == 46
7/16/15 8:55 == 32.7	7/16/15 13:30 == 47	7/16/15 18:05 == 26.7	7/16/15 22:40 == 46
7/16/15 9:00 == 33.2	7/16/15 13:35 == 47.3	7/16/15 18:10 == 30.8	7/16/15 22:45 == 35.1
7/16/15 9:05 == 32.9	7/16/15 13:40 == 47.2	7/16/15 18:15 == 45.5	7/16/15 22:50 == 31.7
7/16/15 9:10 == 32.8	7/16/15 13:45 == 47.1	7/16/15 18:20 == 45.6	7/16/15 22:55 == 31.7
7/16/15 9:15 == 33.1	7/16/15 13:50 == 47.4	7/16/15 18:25 == 45.6	7/16/15 23:00 == 31.9
7/16/15 9:20 == 33	7/16/15 13:55 == 47.1	7/16/15 18:30 == 45.4	7/16/15 23:05 == 32
7/16/15 9:25 == 33	7/16/15 14:00 == 47.1	7/16/15 18:35 == 45.6	7/16/15 23:10 == 32.2
7/16/15 9:30 == 32.9	7/16/15 14:05 == 47.1	7/16/15 18:40 == 45.5	7/16/15 23:15 == 32.4
7/16/15 9:35 == 32.8	7/16/15 14:10 == 47.2	7/16/15 18:45 == 45.6	7/16/15 23:20 == 32.3
7/16/15 9:40 == 33	7/16/15 14:15 == 45.5	7/16/15 18:50 == 45.4	7/16/15 23:25 == 32.3
7/16/15 9:45 == 32.9	7/16/15 14:20 == 46.3	7/16/15 18:55 == 45.6	7/16/15 23:30 == 32.6
7/16/15 9:50 == 32.9	7/16/15 14:25 == 46.9	7/16/15 19:00 == 45.5	7/16/15 23:35 == 32.7
7/16/15 9:55 == 33.1	7/16/15 14:30 == 47.3	7/16/15 19:05 == 45.5	7/16/15 23:40 == 32.8
7/16/15 10:00 == 33	7/16/15 14:35 == 46.8	7/16/15 19:10 == 45.8	7/16/15 23:45 == 32.9
7/16/15 10:05 == 33.2	7/16/15 14:40 == 47.1	7/16/15 19:15 == 45.9	7/16/15 23:50 == 32.8
7/16/15 10:10 == 33.2	7/16/15 14:45 == 36.9	7/16/15 19:20 == 45.9	7/16/15 23:55 == 32.8
7/16/15 10:15 == 36.9	7/16/15 14:50 == 32.2	7/16/15 19:25 == 45.7	7/17/15 0:00 == 32.9
7/16/15 10:20 == 47.3	7/16/15 14:55 == 32	7/16/15 19:30 == 45.8	7/17/15 0:05 == 32.9
7/16/15 10:25 == 47.2	7/16/15 15:00 == 32.5	7/16/15 19:35 == 45.7	7/17/15 0:10 == 33
7/16/15 10:30 == 47	7/16/15 15:05 == 32.5	7/16/15 19:40 == 45.9	7/17/15 0:15 == 37.5
7/16/15 10:35 == 46.9	7/16/15 15:10 == 32.6	7/16/15 19:45 == 45.7	7/17/15 0:20 == 46.2
7/16/15 10:40 == 47.1	7/16/15 15:15 == 32.9	7/16/15 19:50 == 45.8	7/17/15 0:25 == 46.1
7/16/15 10:45 == 47.1	7/16/15 15:20 == 32.9	7/16/15 19:55 == 45.7	7/17/15 0:30 == 46
7/16/15 10:50 == 47.1	7/16/15 15:25 == 32.8	7/16/15 20:00 == 45.7	7/17/15 0:35 == 46.1
7/16/15 10:55 == 47.1	7/16/15 15:30 == 32.9	7/16/15 20:05 == 45.8	7/17/15 0:40 == 46.1
7/16/15 11:00 == 46.9	7/16/15 15:35 == 33	7/16/15 20:10 == 45.9	7/17/15 0:45 == 46.2
7/16/15 11:05 == 47.3	7/16/15 15:40 == 32.5	7/16/15 20:15 == 34.9	7/17/15 0:50 == 45.9
7/16/15 11:10 == 47.5	7/16/15 15:45 == 37.2	7/16/15 20:20 == 31.6	7/17/15 0:55 == 46.1

Pumpback Station Discharge (0364)

7/17/15 1:00 == 45.9	7/17/15 5:35 == 32.8	7/17/15 10:10 == 33	7/17/15 14:45 == 46.1
7/17/15 1:05 == 46	7/17/15 5:40 == 32.6	7/17/15 10:15 == 37.5	7/17/15 14:50 == 46.2
7/17/15 1:10 == 46.2	7/17/15 5:45 == 37.4	7/17/15 10:20 == 45.9	7/17/15 14:55 == 45.6
7/17/15 1:15 == 34.9	7/17/15 5:50 == 45.6	7/17/15 10:25 == 46.1	7/17/15 15:00 == 45.9
7/17/15 1:20 == 31.6	7/17/15 5:55 == 45.9	7/17/15 10:30 == 46.2	7/17/15 15:05 == 45.6
7/17/15 1:25 == 31.6	7/17/15 6:00 == 45.5	7/17/15 10:35 == 45.7	7/17/15 15:10 == 45.5
7/17/15 1:30 == 32.2	7/17/15 6:05 == 45.8	7/17/15 10:40 == 45.8	7/17/15 15:15 == 45.4
7/17/15 1:35 == 32.2	7/17/15 6:10 == 45.8	7/17/15 10:45 == 46	7/17/15 15:20 == 45.4
7/17/15 1:40 == 32.3	7/17/15 6:15 == 45.5	7/17/15 10:50 == 45.8	7/17/15 15:25 == 45.5
7/17/15 1:45 == 32.3	7/17/15 6:20 == 45.8	7/17/15 10:55 == 46	7/17/15 15:30 == 45.5
7/17/15 1:50 == 32.2	7/17/15 6:25 == 45.8	7/17/15 11:00 == 45.9	7/17/15 15:35 == 45.4
7/17/15 1:55 == 32.2	7/17/15 6:30 == 45.3	7/17/15 11:05 == 45.9	7/17/15 15:40 == 45.5
7/17/15 2:00 == 32.6	7/17/15 6:35 == 46.6	7/17/15 11:10 == 45.9	7/17/15 15:45 == 34.1
7/17/15 2:05 == 32.6	7/17/15 6:40 == 46	7/17/15 11:15 == 45.5	7/17/15 15:50 == 31.1
7/17/15 2:10 == 32.6	7/17/15 6:45 == 34.8	7/17/15 11:20 == 45.5	7/17/15 15:55 == 31.3
7/17/15 2:15 == 32.5	7/17/15 6:50 == 31.6	7/17/15 11:25 == 45.3	7/17/15 16:00 == 31.8
7/17/15 2:20 == 32.7	7/17/15 6:55 == 31.6	7/17/15 11:30 == 45.4	7/17/15 16:05 == 31.8
7/17/15 2:25 == 32.6	7/17/15 7:00 == 31.7	7/17/15 11:35 == 45.2	7/17/15 16:10 == 31.4
7/17/15 2:30 == 37.4	7/17/15 7:05 == 31.5	7/17/15 11:40 == 45.1	7/17/15 16:15 == 31.5
7/17/15 2:35 == 46	7/17/15 7:10 == 31.6	7/17/15 11:45 == 45.3	7/17/15 16:20 == 31.6
7/17/15 2:40 == 45.8	7/17/15 7:15 == 31.6	7/17/15 11:50 == 45.6	7/17/15 16:25 == 31.7
7/17/15 2:45 == 46	7/17/15 7:20 == 31.6	7/17/15 11:55 == 45.1	7/17/15 16:30 == 31.9
7/17/15 2:50 == 45.7	7/17/15 7:25 == 31.7	7/17/15 12:00 == 45.1	7/17/15 16:35 == 32.1
7/17/15 2:55 == 45.8	7/17/15 7:30 == 32	7/17/15 12:05 == 45.1	7/17/15 16:40 == 32.1
7/17/15 3:00 == 45.9	7/17/15 7:35 == 31.6	7/17/15 12:10 == 45.3	7/17/15 16:45 == 32.1
7/17/15 3:05 == 45.8	7/17/15 7:40 == 31.8	7/17/15 12:15 == 45.3	7/17/15 16:50 == 32.2
7/17/15 3:10 == 45.7	7/17/15 7:45 == 31.8	7/17/15 12:20 == 45.5	7/17/15 16:55 == 32.1
7/17/15 3:15 == 46	7/17/15 7:50 == 32	7/17/15 12:25 == 45.1	7/17/15 17:00 == 37.3
7/17/15 3:20 == 45.7	7/17/15 7:55 == 32.1	7/17/15 12:30 == 45.5	7/17/15 17:05 == 44.5
7/17/15 3:25 == 45.8	7/17/15 8:00 == 32.1	7/17/15 12:35 == 45.3	7/17/15 17:10 == 44.3
7/17/15 3:30 == 45.8	7/17/15 8:05 == 32.1	7/17/15 12:40 == 45.1	7/17/15 17:15 == 44.3
7/17/15 3:35 == 45.8	7/17/15 8:10 == 31.4	7/17/15 12:45 == 45.3	7/17/15 17:20 == 44.3
7/17/15 3:40 == 45.7	7/17/15 8:15 == 32	7/17/15 12:50 == 45	7/17/15 17:25 == 44.3
7/17/15 3:45 == 34.6	7/17/15 8:20 == 32.1	7/17/15 12:55 == 45.8	7/17/15 17:30 == 44.3
7/17/15 3:50 == 31.5	7/17/15 8:25 == 32.1	7/17/15 13:00 == 46	7/17/15 17:35 == 44.3
7/17/15 3:55 == 31.4	7/17/15 8:30 == 32.2	7/17/15 13:05 == 46	7/17/15 17:40 == 44.1
7/17/15 4:00 == 31.9	7/17/15 8:35 == 32.2	7/17/15 13:10 == 46	7/17/15 17:45 == 44.2
7/17/15 4:05 == 32	7/17/15 8:40 == 32	7/17/15 13:15 == 46.2	7/17/15 17:50 == 44.2
7/17/15 4:10 == 31.9	7/17/15 8:45 == 32.4	7/17/15 13:20 == 45.8	7/17/15 17:55 == 44.2
7/17/15 4:15 == 32	7/17/15 8:50 == 32.5	7/17/15 13:25 == 46	7/17/15 18:00 == 44.1
7/17/15 4:20 == 32.1	7/17/15 8:55 == 32.5	7/17/15 13:30 == 34.8	7/17/15 18:05 == 44.2
7/17/15 4:25 == 32	7/17/15 9:00 == 32.5	7/17/15 13:35 == 31.9	7/17/15 18:10 == 44.1
7/17/15 4:30 == 32.3	7/17/15 9:05 == 32.5	7/17/15 13:40 == 31.7	7/17/15 18:15 == 44.1
7/17/15 4:35 == 32.4	7/17/15 9:10 == 32.4	7/17/15 13:45 == 32.1	7/17/15 18:20 == 44.1
7/17/15 4:40 == 32.3	7/17/15 9:15 == 32.8	7/17/15 13:50 == 32.3	7/17/15 18:25 == 44.3
7/17/15 4:45 == 32.6	7/17/15 9:20 == 32.1	7/17/15 13:55 == 32.2	7/17/15 18:30 == 33
7/17/15 4:50 == 32.6	7/17/15 9:25 == 32.5	7/17/15 14:00 == 32.5	7/17/15 18:35 == 31.1
7/17/15 4:55 == 32.6	7/17/15 9:30 == 32.5	7/17/15 14:05 == 32.6	7/17/15 18:40 == 31
7/17/15 5:00 == 32.8	7/17/15 9:35 == 32.6	7/17/15 14:10 == 32.6	7/17/15 18:45 == 31.3
7/17/15 5:05 == 32.6	7/17/15 9:40 == 32.4	7/17/15 14:15 == 32.7	7/17/15 18:50 == 31.5
7/17/15 5:10 == 32.5	7/17/15 9:45 == 32.7	7/17/15 14:20 == 32.6	7/17/15 18:55 == 31.5
7/17/15 5:15 == 32.7	7/17/15 9:50 == 32.8	7/17/15 14:25 == 32.7	7/17/15 19:00 == 31.8
7/17/15 5:20 == 32.8	7/17/15 9:55 == 32.8	7/17/15 14:30 == 38.2	7/17/15 19:05 == 31.8
7/17/15 5:25 == 32.7	7/17/15 10:00 == 32.9	7/17/15 14:35 == 46.3	7/17/15 19:10 == 31.8
7/17/15 5:30 == 32.8	7/17/15 10:05 == 32.9	7/17/15 14:40 == 46.3	7/17/15 19:15 == 32

Pumpback Station Discharge (0364)

7/17/15 19:20 == 32	7/17/15 23:55 == 44.2	7/18/15 4:30 == 26.1	7/18/15 9:05 == 44.3
7/17/15 19:25 == 32.1	7/18/15 0:00 == 32.6	7/18/15 4:35 == 26.2	7/18/15 9:10 == 44.3
7/17/15 19:30 == 37.6	7/18/15 0:05 == 31	7/18/15 4:40 == 26.2	7/18/15 9:15 == 44.4
7/17/15 19:35 == 44.5	7/18/15 0:10 == 30.9	7/18/15 4:45 == 26.2	7/18/15 9:20 == 44.3
7/17/15 19:40 == 44.1	7/18/15 0:15 == 31.4	7/18/15 4:50 == 26.2	7/18/15 9:25 == 44.3
7/17/15 19:45 == 44.2	7/18/15 0:20 == 31.4	7/18/15 4:55 == 26.2	7/18/15 9:30 == 32.4
7/17/15 19:50 == 44.2	7/18/15 0:25 == 31.4	7/18/15 5:00 == 26.3	7/18/15 9:35 == 30.9
7/17/15 19:55 == 44.2	7/18/15 0:30 == 31.5	7/18/15 5:05 == 26.1	7/18/15 9:40 == 31.1
7/17/15 20:00 == 44.1	7/18/15 0:35 == 31.7	7/18/15 5:10 == 26.2	7/18/15 9:45 == 31.6
7/17/15 20:05 == 44.2	7/18/15 0:40 == 31.7	7/18/15 5:15 == 26.2	7/18/15 9:50 == 31.8
7/17/15 20:10 == 44	7/18/15 0:45 == 32	7/18/15 5:20 == 26.2	7/18/15 9:55 == 31.6
7/17/15 20:15 == 44.2	7/18/15 0:50 == 32	7/18/15 5:25 == 26.2	7/18/15 10:00 == 32
7/17/15 20:20 == 44.2	7/18/15 0:55 == 32	7/18/15 5:30 == 26.3	7/18/15 10:05 == 32.1
7/17/15 20:25 == 44.3	7/18/15 1:00 == 32.3	7/18/15 5:35 == 26.2	7/18/15 10:10 == 32
7/17/15 20:30 == 44.1	7/18/15 1:05 == 32	7/18/15 5:40 == 26.3	7/18/15 10:15 == 32.3
7/17/15 20:35 == 44.2	7/18/15 1:10 == 32.2	7/18/15 5:45 == 26.2	7/18/15 10:20 == 32.3
7/17/15 20:40 == 44.1	7/18/15 1:15 == 37.7	7/18/15 5:50 == 26.4	7/18/15 10:25 == 32.5
7/17/15 20:45 == 44.1	7/18/15 1:20 == 44.5	7/18/15 5:55 == 26.3	7/18/15 10:30 == 38.4
7/17/15 20:50 == 44.3	7/18/15 1:25 == 44.2	7/18/15 6:00 == 26.3	7/18/15 10:35 == 44.9
7/17/15 20:55 == 44.2	7/18/15 1:30 == 44.2	7/18/15 6:05 == 28.3	7/18/15 10:40 == 44.7
7/17/15 21:00 == 44.3	7/18/15 1:35 == 44.2	7/18/15 6:10 == 44.3	7/18/15 10:45 == 44.9
7/17/15 21:05 == 44	7/18/15 1:40 == 44.1	7/18/15 6:15 == 44.5	7/18/15 10:50 == 44.8
7/17/15 21:10 == 44	7/18/15 1:45 == 44.1	7/18/15 6:20 == 44.4	7/18/15 10:55 == 44.9
7/17/15 21:15 == 32.6	7/18/15 1:50 == 44.1	7/18/15 6:25 == 44.5	7/18/15 11:00 == 44.9
7/17/15 21:20 == 31.1	7/18/15 1:55 == 44.1	7/18/15 6:30 == 44.2	7/18/15 11:05 == 44.8
7/17/15 21:25 == 30.9	7/18/15 2:00 == 44.1	7/18/15 6:35 == 44.3	7/18/15 11:10 == 44.9
7/17/15 21:30 == 31.4	7/18/15 2:05 == 44.1	7/18/15 6:40 == 44.3	7/18/15 11:15 == 44.9
7/17/15 21:35 == 31.5	7/18/15 2:10 == 44.1	7/18/15 6:45 == 44.3	7/18/15 11:20 == 44.8
7/17/15 21:40 == 31.4	7/18/15 2:15 == 44.2	7/18/15 6:50 == 44.2	7/18/15 11:25 == 44.9
7/17/15 21:45 == 31.7	7/18/15 2:20 == 44.1	7/18/15 6:55 == 44.1	7/18/15 11:30 == 44.9
7/17/15 21:50 == 31.7	7/18/15 2:25 == 44.3	7/18/15 7:00 == 44.2	7/18/15 11:35 == 44.8
7/17/15 21:55 == 31.7	7/18/15 2:30 == 43.9	7/18/15 7:05 == 44.2	7/18/15 11:40 == 44.8
7/17/15 22:00 == 31.9	7/18/15 2:35 == 44	7/18/15 7:10 == 44.3	7/18/15 11:45 == 44.7
7/17/15 22:05 == 31.9	7/18/15 2:40 == 44	7/18/15 7:15 == 44.4	7/18/15 11:50 == 44.9
7/17/15 22:10 == 31.8	7/18/15 2:45 == 44.1	7/18/15 7:20 == 44.2	7/18/15 11:55 == 44.7
7/17/15 22:15 == 32.2	7/18/15 2:50 == 44	7/18/15 7:25 == 44.1	7/18/15 12:00 == 44.8
7/17/15 22:20 == 32.1	7/18/15 2:55 == 44.1	7/18/15 7:30 == 44.2	7/18/15 12:05 == 44.8
7/17/15 22:25 == 32.3	7/18/15 3:00 == 32.5	7/18/15 7:35 == 44.2	7/18/15 12:10 == 44.9
7/17/15 22:30 == 37.6	7/18/15 3:05 == 30.8	7/18/15 7:40 == 44.4	7/18/15 12:15 == 44.8
7/17/15 22:35 == 44.3	7/18/15 3:10 == 30.9	7/18/15 7:45 == 44.1	7/18/15 12:20 == 44.7
7/17/15 22:40 == 44.4	7/18/15 3:15 == 31.3	7/18/15 7:50 == 44.3	7/18/15 12:25 == 45
7/17/15 22:45 == 44.3	7/18/15 3:20 == 31.4	7/18/15 7:55 == 44.1	7/18/15 12:30 == 44.7
7/17/15 22:50 == 44.2	7/18/15 3:25 == 31.3	7/18/15 8:00 == 44.1	7/18/15 12:35 == 44.9
7/17/15 22:55 == 44.2	7/18/15 3:30 == 31.7	7/18/15 8:05 == 44.2	7/18/15 12:40 == 44.8
7/17/15 23:00 == 44.2	7/18/15 3:35 == 31.7	7/18/15 8:10 == 44.2	7/18/15 12:45 == 44.8
7/17/15 23:05 == 44.1	7/18/15 3:40 == 31.7	7/18/15 8:15 == 44.3	7/18/15 12:50 == 44.8
7/17/15 23:10 == 44.2	7/18/15 3:45 == 31.9	7/18/15 8:20 == 44.1	7/18/15 12:55 == 44.8
7/17/15 23:15 == 44	7/18/15 3:50 == 32	7/18/15 8:25 == 44.3	7/18/15 13:00 == 44.9
7/17/15 23:20 == 44.1	7/18/15 3:55 == 31.8	7/18/15 8:30 == 44.1	7/18/15 13:05 == 44.8
7/17/15 23:25 == 44.1	7/18/15 4:00 == 32.2	7/18/15 8:35 == 44.1	7/18/15 13:10 == 44.8
7/17/15 23:30 == 44.2	7/18/15 4:05 == 32.1	7/18/15 8:40 == 44	7/18/15 13:15 == 44.9
7/17/15 23:35 == 44.2	7/18/15 4:10 == 32.2	7/18/15 8:45 == 44.1	7/18/15 13:20 == 44.7
7/17/15 23:40 == 44.1	7/18/15 4:15 == 26.9	7/18/15 8:50 == 44.1	7/18/15 13:25 == 44.8
7/17/15 23:45 == 44.1	7/18/15 4:20 == 26.1	7/18/15 8:55 == 44.2	7/18/15 13:30 == 44.9
7/17/15 23:50 == 44.1	7/18/15 4:25 == 26.2	7/18/15 9:00 == 44.4	7/18/15 13:35 == 44.9

Pumpback Station Discharge (0364)

7/18/15 13:40 == 44.9	7/18/15 18:15 == 44.9	7/18/15 22:50 == 32.3	7/19/15 3:25 == 44.8
7/18/15 13:45 == 32	7/18/15 18:20 == 45	7/18/15 22:55 == 32.2	7/19/15 3:30 == 31.5
7/18/15 13:50 == 31.3	7/18/15 18:25 == 45	7/18/15 23:00 == 32.4	7/19/15 3:35 == 31.2
7/18/15 13:55 == 31.1	7/18/15 18:30 == 44.9	7/18/15 23:05 == 32.4	7/19/15 3:40 == 31.1
7/18/15 14:00 == 31.6	7/18/15 18:35 == 44.9	7/18/15 23:10 == 32.4	7/19/15 3:45 == 31.7
7/18/15 14:05 == 31.7	7/18/15 18:40 == 45	7/18/15 23:15 == 39.8	7/19/15 3:50 == 31.6
7/18/15 14:10 == 31.7	7/18/15 18:45 == 44.8	7/18/15 23:20 == 44.8	7/19/15 3:55 == 31.7
7/18/15 14:15 == 31.9	7/18/15 18:50 == 44.7	7/18/15 23:25 == 44.9	7/19/15 4:00 == 32
7/18/15 14:20 == 32	7/18/15 18:55 == 44.8	7/18/15 23:30 == 44.9	7/19/15 4:05 == 32
7/18/15 14:25 == 32.1	7/18/15 19:00 == 44.8	7/18/15 23:35 == 44.9	7/19/15 4:10 == 32
7/18/15 14:30 == 32.2	7/18/15 19:05 == 44.9	7/18/15 23:40 == 44.9	7/19/15 4:15 == 32.2
7/18/15 14:35 == 32.3	7/18/15 19:10 == 44.8	7/18/15 23:45 == 45	7/19/15 4:20 == 32.2
7/18/15 14:40 == 32.3	7/18/15 19:15 == 45	7/18/15 23:50 == 45	7/19/15 4:25 == 32.1
7/18/15 14:45 == 32.4	7/18/15 19:20 == 44.9	7/18/15 23:55 == 44.8	7/19/15 4:30 == 32.4
7/18/15 14:50 == 32.4	7/18/15 19:25 == 44.9	7/19/15 0:00 == 44.8	7/19/15 4:35 == 32.4
7/18/15 14:55 == 32.3	7/18/15 19:30 == 31.8	7/19/15 0:05 == 44.9	7/19/15 4:40 == 32.5
7/18/15 15:00 == 39	7/18/15 19:35 == 31.3	7/19/15 0:10 == 44.9	7/19/15 4:45 == 39.6
7/18/15 15:05 == 45.1	7/18/15 19:40 == 31.3	7/19/15 0:15 == 44.8	7/19/15 4:50 == 44.9
7/18/15 15:10 == 45	7/18/15 19:45 == 31.8	7/19/15 0:20 == 44.8	7/19/15 4:55 == 44.9
7/18/15 15:15 == 45.1	7/18/15 19:50 == 31.9	7/19/15 0:25 == 44.8	7/19/15 5:00 == 45
7/18/15 15:20 == 44.8	7/18/15 19:55 == 31.8	7/19/15 0:30 == 44.9	7/19/15 5:05 == 45
7/18/15 15:25 == 44.9	7/18/15 20:00 == 32.1	7/19/15 0:35 == 44.8	7/19/15 5:10 == 44.9
7/18/15 15:30 == 44.9	7/18/15 20:05 == 32.1	7/19/15 0:40 == 45	7/19/15 5:15 == 45.1
7/18/15 15:35 == 44.9	7/18/15 20:10 == 32.1	7/19/15 0:45 == 31.6	7/19/15 5:20 == 44.9
7/18/15 15:40 == 45	7/18/15 20:15 == 32.3	7/19/15 0:50 == 31.2	7/19/15 5:25 == 44.9
7/18/15 15:45 == 45	7/18/15 20:20 == 32.3	7/19/15 0:55 == 31.3	7/19/15 5:30 == 45
7/18/15 15:50 == 45.1	7/18/15 20:25 == 32.3	7/19/15 1:00 == 31.7	7/19/15 5:35 == 44.9
7/18/15 15:55 == 44.8	7/18/15 20:30 == 39.6	7/19/15 1:05 == 31.6	7/19/15 5:40 == 44.9
7/18/15 16:00 == 44.9	7/18/15 20:35 == 44.9	7/19/15 1:10 == 31.7	7/19/15 5:45 == 44.9
7/18/15 16:05 == 44.9	7/18/15 20:40 == 45.1	7/19/15 1:15 == 32	7/19/15 5:50 == 44.9
7/18/15 16:10 == 44.9	7/18/15 20:45 == 44.9	7/19/15 1:20 == 31.8	7/19/15 5:55 == 44.9
7/18/15 16:15 == 44.9	7/18/15 20:50 == 44.9	7/19/15 1:25 == 32	7/19/15 6:00 == 44.9
7/18/15 16:20 == 44.8	7/18/15 20:55 == 44.9	7/19/15 1:30 == 32.2	7/19/15 6:05 == 44.9
7/18/15 16:25 == 44.9	7/18/15 21:00 == 45	7/19/15 1:35 == 32.3	7/19/15 6:10 == 44.8
7/18/15 16:30 == 31.7	7/18/15 21:05 == 44.9	7/19/15 1:40 == 32.3	7/19/15 6:15 == 31.4
7/18/15 16:35 == 31.2	7/18/15 21:10 == 44.9	7/19/15 1:45 == 32.5	7/19/15 6:20 == 31.1
7/18/15 16:40 == 31.3	7/18/15 21:15 == 45	7/19/15 1:50 == 32.3	7/19/15 6:25 == 31.2
7/18/15 16:45 == 31.6	7/18/15 21:20 == 44.7	7/19/15 1:55 == 32.4	7/19/15 6:30 == 31.5
7/18/15 16:50 == 31.6	7/18/15 21:25 == 44.7	7/19/15 2:00 == 39.8	7/19/15 6:35 == 31.7
7/18/15 16:55 == 31.7	7/18/15 21:30 == 44.8	7/19/15 2:05 == 44.9	7/19/15 6:40 == 31.6
7/18/15 17:00 == 32	7/18/15 21:35 == 44.9	7/19/15 2:10 == 45	7/19/15 6:45 == 31.7
7/18/15 17:05 == 32	7/18/15 21:40 == 44.8	7/19/15 2:15 == 44.9	7/19/15 6:50 == 31.8
7/18/15 17:10 == 32.1	7/18/15 21:45 == 44.8	7/19/15 2:20 == 44.9	7/19/15 6:55 == 31.8
7/18/15 17:15 == 32.4	7/18/15 21:50 == 44.9	7/19/15 2:25 == 44.9	7/19/15 7:00 == 31.8
7/18/15 17:20 == 32.2	7/18/15 21:55 == 44.8	7/19/15 2:30 == 44.9	7/19/15 7:05 == 31.7
7/18/15 17:25 == 32.2	7/18/15 22:00 == 31.6	7/19/15 2:35 == 44.9	7/19/15 7:10 == 31.8
7/18/15 17:30 == 32.5	7/18/15 22:05 == 31.1	7/19/15 2:40 == 45	7/19/15 7:15 == 31.5
7/18/15 17:35 == 32.5	7/18/15 22:10 == 31.1	7/19/15 2:45 == 44.8	7/19/15 7:20 == 31.6
7/18/15 17:40 == 32.5	7/18/15 22:15 == 31.7	7/19/15 2:50 == 44.8	7/19/15 7:25 == 31.6
7/18/15 17:45 == 32.5	7/18/15 22:20 == 31.7	7/19/15 2:55 == 44.9	7/19/15 7:30 == 31.3
7/18/15 17:50 == 32.6	7/18/15 22:25 == 31.6	7/19/15 3:00 == 44.9	7/19/15 7:35 == 31.4
7/18/15 17:55 == 32.5	7/18/15 22:30 == 32.1	7/19/15 3:05 == 44.8	7/19/15 7:40 == 31.3
7/18/15 18:00 == 39.5	7/18/15 22:35 == 32.1	7/19/15 3:10 == 44.8	7/19/15 7:45 == 31.6
7/18/15 18:05 == 44.9	7/18/15 22:40 == 32.2	7/19/15 3:15 == 45	7/19/15 7:50 == 31.6
7/18/15 18:10 == 45.1	7/18/15 22:45 == 32.2	7/19/15 3:20 == 44.7	7/19/15 7:55 == 31.7

Pumpback Station Discharge (0364)

7/19/15 8:00 == 32	7/19/15 12:35 == 45.2	7/19/15 17:10 == 44.9	7/19/15 21:45 == 31.9
7/19/15 8:05 == 32.2	7/19/15 12:40 == 45	7/19/15 17:15 == 44.9	7/19/15 21:50 == 32
7/19/15 8:10 == 32	7/19/15 12:45 == 45	7/19/15 17:20 == 44.9	7/19/15 21:55 == 32.1
7/19/15 8:15 == 31.9	7/19/15 12:50 == 45	7/19/15 17:25 == 44.8	7/19/15 22:00 == 32.4
7/19/15 8:20 == 31.8	7/19/15 12:55 == 45	7/19/15 17:30 == 45	7/19/15 22:05 == 32.3
7/19/15 8:25 == 32	7/19/15 13:00 == 45.1	7/19/15 17:35 == 44.8	7/19/15 22:10 == 31.8
7/19/15 8:30 == 32	7/19/15 13:05 == 45.3	7/19/15 17:40 == 44.8	7/19/15 22:15 == 41.5
7/19/15 8:35 == 31.9	7/19/15 13:10 == 44.8	7/19/15 17:45 == 44.9	7/19/15 22:20 == 44.9
7/19/15 8:40 == 32.2	7/19/15 13:15 == 45	7/19/15 17:50 == 45	7/19/15 22:25 == 45
7/19/15 8:45 == 32.3	7/19/15 13:20 == 45	7/19/15 17:55 == 43.6	7/19/15 22:30 == 45
7/19/15 8:50 == 32.3	7/19/15 13:25 == 45.3	7/19/15 18:00 == 31.5	7/19/15 22:35 == 45
7/19/15 8:55 == 32.2	7/19/15 13:30 == 45	7/19/15 18:05 == 31.3	7/19/15 22:40 == 45
7/19/15 9:00 == 32.3	7/19/15 13:35 == 44.8	7/19/15 18:10 == 31.3	7/19/15 22:45 == 45
7/19/15 9:05 == 32.3	7/19/15 13:40 == 45.3	7/19/15 18:15 == 31.8	7/19/15 22:50 == 44.9
7/19/15 9:10 == 32.3	7/19/15 13:45 == 44.9	7/19/15 18:20 == 31.9	7/19/15 22:55 == 44.9
7/19/15 9:15 == 32.4	7/19/15 13:50 == 44.8	7/19/15 18:25 == 31.9	7/19/15 23:00 == 44.8
7/19/15 9:20 == 32.3	7/19/15 13:55 == 44.9	7/19/15 18:30 == 32.1	7/19/15 23:05 == 44.9
7/19/15 9:25 == 32.4	7/19/15 14:00 == 45.3	7/19/15 18:35 == 32	7/19/15 23:10 == 44.8
7/19/15 9:30 == 32.6	7/19/15 14:05 == 45.4	7/19/15 18:40 == 31.5	7/19/15 23:15 == 44.8
7/19/15 9:35 == 32.6	7/19/15 14:10 == 44.6	7/19/15 18:45 == 41.5	7/19/15 23:20 == 45
7/19/15 9:40 == 32.5	7/19/15 14:15 == 44.9	7/19/15 18:50 == 45	7/19/15 23:25 == 45
7/19/15 9:45 == 40.1	7/19/15 14:20 == 44.9	7/19/15 18:55 == 45	7/19/15 23:30 == 45.1
7/19/15 9:50 == 45.1	7/19/15 14:25 == 45	7/19/15 19:00 == 45	7/19/15 23:35 == 44.9
7/19/15 9:55 == 45.3	7/19/15 14:30 == 45	7/19/15 19:05 == 44.9	7/19/15 23:40 == 44.9
7/19/15 10:00 == 45.2	7/19/15 14:35 == 44.9	7/19/15 19:10 == 44.9	7/19/15 23:45 == 44.9
7/19/15 10:05 == 45.4	7/19/15 14:40 == 44.8	7/19/15 19:15 == 44.9	7/19/15 23:50 == 45
7/19/15 10:10 == 45	7/19/15 14:45 == 45	7/19/15 19:20 == 45	7/19/15 23:55 == 43.7
7/19/15 10:15 == 45.2	7/19/15 14:50 == 45.1	7/19/15 19:25 == 44.9	7/20/15 0:00 == 31.4
7/19/15 10:20 == 45.1	7/19/15 14:55 == 43.6	7/19/15 19:30 == 45	7/20/15 0:05 == 31.3
7/19/15 10:25 == 45.1	7/19/15 15:00 == 31.7	7/19/15 19:35 == 44.7	7/20/15 0:10 == 31.3
7/19/15 10:30 == 45	7/19/15 15:05 == 31.3	7/19/15 19:40 == 44.9	7/20/15 0:15 == 31.8
7/19/15 10:35 == 45	7/19/15 15:10 == 31.2	7/19/15 19:45 == 45	7/20/15 0:20 == 31.8
7/19/15 10:40 == 45.1	7/19/15 15:15 == 31.8	7/19/15 19:50 == 44.9	7/20/15 0:25 == 31.9
7/19/15 10:45 == 45.2	7/19/15 15:20 == 31.8	7/19/15 19:55 == 44.8	7/20/15 0:30 == 32.2
7/19/15 10:50 == 45.2	7/19/15 15:25 == 31.9	7/19/15 20:00 == 44.9	7/20/15 0:35 == 32.1
7/19/15 10:55 == 45.1	7/19/15 15:30 == 32.3	7/19/15 20:05 == 45	7/20/15 0:40 == 32.2
7/19/15 11:00 == 45.2	7/19/15 15:35 == 32.2	7/19/15 20:10 == 44.9	7/20/15 0:45 == 32.6
7/19/15 11:05 == 45.1	7/19/15 15:40 == 32.2	7/19/15 20:15 == 44.8	7/20/15 0:50 == 32.5
7/19/15 11:10 == 45.1	7/19/15 15:45 == 32.5	7/19/15 20:20 == 44.9	7/20/15 0:55 == 32
7/19/15 11:15 == 45.1	7/19/15 15:50 == 32.3	7/19/15 20:25 == 45	7/20/15 1:00 == 41.5
7/19/15 11:20 == 45	7/19/15 15:55 == 31.8	7/19/15 20:30 == 44.9	7/20/15 1:05 == 44.8
7/19/15 11:25 == 45	7/19/15 16:00 == 41.7	7/19/15 20:35 == 44.9	7/20/15 1:10 == 44.9
7/19/15 11:30 == 45.2	7/19/15 16:05 == 45.1	7/19/15 20:40 == 44.8	7/20/15 1:15 == 44.9
7/19/15 11:35 == 45	7/19/15 16:10 == 44.9	7/19/15 20:45 == 44.9	7/20/15 1:20 == 44.9
7/19/15 11:40 == 45.1	7/19/15 16:15 == 45.6	7/19/15 20:50 == 44.9	7/20/15 1:25 == 44.8
7/19/15 11:45 == 45.1	7/19/15 16:20 == 44.9	7/19/15 20:55 == 45	7/20/15 1:30 == 45
7/19/15 11:50 == 45	7/19/15 16:25 == 45	7/19/15 21:00 == 44.8	7/20/15 1:35 == 44.8
7/19/15 11:55 == 45.1	7/19/15 16:30 == 45.1	7/19/15 21:05 == 44.9	7/20/15 1:40 == 44.9
7/19/15 12:00 == 45	7/19/15 16:35 == 45	7/19/15 21:10 == 43.7	7/20/15 1:45 == 44.9
7/19/15 12:05 == 45.1	7/19/15 16:40 == 44.9	7/19/15 21:15 == 31.4	7/20/15 1:50 == 44.9
7/19/15 12:10 == 44.8	7/19/15 16:45 == 45	7/19/15 21:20 == 31.2	7/20/15 1:55 == 44.9
7/19/15 12:15 == 45	7/19/15 16:50 == 45	7/19/15 21:25 == 31.1	7/20/15 2:00 == 44.8
7/19/15 12:20 == 44.9	7/19/15 16:55 == 45.2	7/19/15 21:30 == 31.6	7/20/15 2:05 == 44.9
7/19/15 12:25 == 45.1	7/19/15 17:00 == 45	7/19/15 21:35 == 31.5	7/20/15 2:10 == 44.9
7/19/15 12:30 == 45.1	7/19/15 17:05 == 44.8	7/19/15 21:40 == 31.5	7/20/15 2:15 == 44.9

Pumpback Station Discharge (0364)

7/20/15 2:20 == 44.9	7/20/15 6:55 == 45.6	7/20/15 11:30 == 32.2	7/20/15 16:05 == 44.6
7/20/15 2:25 == 45	7/20/15 7:00 == 45.4	7/20/15 11:35 == 32.2	7/20/15 16:10 == 44.6
7/20/15 2:30 == 44.9	7/20/15 7:05 == 44.9	7/20/15 11:40 == 31.2	7/20/15 16:15 == 44.5
7/20/15 2:35 == 44.9	7/20/15 7:10 == 45	7/20/15 11:45 == 42.4	7/20/15 16:20 == 44.8
7/20/15 2:40 == 43.6	7/20/15 7:15 == 45.1	7/20/15 11:50 == 44.1	7/20/15 16:25 == 44.5
7/20/15 2:45 == 31.6	7/20/15 7:20 == 45.1	7/20/15 11:55 == 44.3	7/20/15 16:30 == 44.6
7/20/15 2:50 == 31.2	7/20/15 7:25 == 43.1	7/20/15 12:00 == 44.2	7/20/15 16:35 == 44.6
7/20/15 2:55 == 31.4	7/20/15 7:30 == 31.5	7/20/15 12:05 == 44.2	7/20/15 16:40 == 44.6
7/20/15 3:00 == 31.7	7/20/15 7:35 == 31.3	7/20/15 12:10 == 44.2	7/20/15 16:45 == 44.6
7/20/15 3:05 == 31.8	7/20/15 7:40 == 31.3	7/20/15 12:15 == 44.2	7/20/15 16:50 == 44.5
7/20/15 3:10 == 31.8	7/20/15 7:45 == 31.8	7/20/15 12:20 == 44.2	7/20/15 16:55 == 44.6
7/20/15 3:15 == 32.2	7/20/15 7:50 == 31.8	7/20/15 12:25 == 44	7/20/15 17:00 == 44.5
7/20/15 3:20 == 32.1	7/20/15 7:55 == 31.8	7/20/15 12:30 == 44.2	7/20/15 17:05 == 44.5
7/20/15 3:25 == 31.7	7/20/15 8:00 == 32.2	7/20/15 12:35 == 44.1	7/20/15 17:10 == 44.6
7/20/15 3:30 == 41.6	7/20/15 8:05 == 32.3	7/20/15 12:40 == 44.1	7/20/15 17:15 == 44.5
7/20/15 3:35 == 44.8	7/20/15 8:10 == 31.5	7/20/15 12:45 == 44.1	7/20/15 17:20 == 44.5
7/20/15 3:40 == 45.1	7/20/15 8:15 == 41.7	7/20/15 12:50 == 44.2	7/20/15 17:25 == 44.6
7/20/15 3:45 == 44.9	7/20/15 8:20 == 44.9	7/20/15 12:55 == 44.3	7/20/15 17:30 == 44.5
7/20/15 3:50 == 44.9	7/20/15 8:25 == 44.2	7/20/15 13:00 == 44	7/20/15 17:35 == 44.6
7/20/15 3:55 == 45	7/20/15 8:30 == 44.2	7/20/15 13:05 == 44.2	7/20/15 17:40 == 44.4
7/20/15 4:00 == 44.9	7/20/15 8:35 == 44.1	7/20/15 13:10 == 44.1	7/20/15 17:45 == 44.7
7/20/15 4:05 == 45	7/20/15 8:40 == 44.3	7/20/15 13:15 == 44.2	7/20/15 17:50 == 44.5
7/20/15 4:10 == 44.9	7/20/15 8:45 == 44.1	7/20/15 13:20 == 44.1	7/20/15 17:55 == 44.6
7/20/15 4:15 == 44.9	7/20/15 8:50 == 44.2	7/20/15 13:25 == 44.1	7/20/15 18:00 == 44.5
7/20/15 4:20 == 45	7/20/15 8:55 == 44.3	7/20/15 13:30 == 44.1	7/20/15 18:05 == 44.6
7/20/15 4:25 == 44.9	7/20/15 9:00 == 44	7/20/15 13:35 == 44.3	7/20/15 18:10 == 44.5
7/20/15 4:30 == 44.9	7/20/15 9:05 == 44.2	7/20/15 13:40 == 44.1	7/20/15 18:15 == 44.6
7/20/15 4:35 == 44.9	7/20/15 9:10 == 44.1	7/20/15 13:45 == 44.1	7/20/15 18:20 == 44.7
7/20/15 4:40 == 45	7/20/15 9:15 == 44.2	7/20/15 13:50 == 44.1	7/20/15 18:25 == 44.5
7/20/15 4:45 == 44.9	7/20/15 9:20 == 44	7/20/15 13:55 == 44.1	7/20/15 18:30 == 44.5
7/20/15 4:50 == 44.9	7/20/15 9:25 == 44.2	7/20/15 14:00 == 44.1	7/20/15 18:35 == 44.5
7/20/15 4:55 == 44.9	7/20/15 9:30 == 44.2	7/20/15 14:05 == 44.1	7/20/15 18:40 == 44.6
7/20/15 5:00 == 44.7	7/20/15 9:35 == 44.1	7/20/15 14:10 == 44.2	7/20/15 18:45 == 44.5
7/20/15 5:05 == 44.9	7/20/15 9:40 == 44.1	7/20/15 14:15 == 44.1	7/20/15 18:50 == 44.5
7/20/15 5:10 == 43.4	7/20/15 9:45 == 44.1	7/20/15 14:20 == 44.3	7/20/15 18:55 == 44.5
7/20/15 5:15 == 31.5	7/20/15 9:50 == 44.4	7/20/15 14:25 == 44.1	7/20/15 19:00 == 44.5
7/20/15 5:20 == 31.1	7/20/15 9:55 == 44.3	7/20/15 14:30 == 44.1	7/20/15 19:05 == 44.5
7/20/15 5:25 == 31.4	7/20/15 10:00 == 44.3	7/20/15 14:35 == 44.4	7/20/15 19:10 == 44.6
7/20/15 5:30 == 31.9	7/20/15 10:05 == 44	7/20/15 14:40 == 44.2	7/20/15 19:15 == 44.5
7/20/15 5:35 == 31.8	7/20/15 10:10 == 44.2	7/20/15 14:45 == 44.3	7/20/15 19:20 == 44.5
7/20/15 5:40 == 32	7/20/15 10:15 == 44.1	7/20/15 14:50 == 44.3	7/20/15 19:25 == 44.6
7/20/15 5:45 == 32.1	7/20/15 10:20 == 44.1	7/20/15 14:55 == 44.4	7/20/15 19:30 == 44.6
7/20/15 5:50 == 32.2	7/20/15 10:25 == 42.2	7/20/15 15:00 == 44.3	7/20/15 19:35 == 44.5
7/20/15 5:55 == 31.7	7/20/15 10:30 == 31.1	7/20/15 15:05 == 44.4	7/20/15 19:40 == 44.5
7/20/15 6:00 == 42	7/20/15 10:35 == 30.8	7/20/15 15:10 == 44.6	7/20/15 19:45 == 44.7
7/20/15 6:05 == 44.9	7/20/15 10:40 == 31	7/20/15 15:15 == 44.3	7/20/15 19:50 == 44.5
7/20/15 6:10 == 45.1	7/20/15 10:45 == 31.4	7/20/15 15:20 == 44.5	7/20/15 19:55 == 44.5
7/20/15 6:15 == 45.6	7/20/15 10:50 == 31.3	7/20/15 15:25 == 44.6	7/20/15 20:00 == 44.6
7/20/15 6:20 == 45.4	7/20/15 10:55 == 31.3	7/20/15 15:30 == 44.5	7/20/15 20:05 == 44.6
7/20/15 6:25 == 45.3	7/20/15 11:00 == 31.4	7/20/15 15:35 == 44.6	7/20/15 20:10 == 44.6
7/20/15 6:30 == 45.5	7/20/15 11:05 == 31.5	7/20/15 15:40 == 44.6	7/20/15 20:15 == 44.5
7/20/15 6:35 == 45.4	7/20/15 11:10 == 31.6	7/20/15 15:45 == 44.7	7/20/15 20:20 == 44.6
7/20/15 6:40 == 45.4	7/20/15 11:15 == 32.1	7/20/15 15:50 == 44.4	7/20/15 20:25 == 44.4
7/20/15 6:45 == 45.4	7/20/15 11:20 == 31.8	7/20/15 15:55 == 44.6	7/20/15 20:30 == 44.6
7/20/15 6:50 == 45.4	7/20/15 11:25 == 32	7/20/15 16:00 == 44.6	7/20/15 20:35 == 44.5

Pumpback Station Discharge (0364)

7/20/15 20:40 == 44.6	7/21/15 1:15 == 26.3	7/21/15 5:50 == 45	7/21/15 10:25 == 44.7
7/20/15 20:45 == 44.5	7/21/15 1:20 == 26.3	7/21/15 5:55 == 45	7/21/15 10:30 == 46.2
7/20/15 20:50 == 44.5	7/21/15 1:25 == 26.4	7/21/15 6:00 == 45.1	7/21/15 10:35 == 46.4
7/20/15 20:55 == 44.5	7/21/15 1:30 == 26.5	7/21/15 6:05 == 45.3	7/21/15 10:40 == 45.9
7/20/15 21:00 == 44.5	7/21/15 1:35 == 26.4	7/21/15 6:10 == 45.7	7/21/15 10:45 == 46.1
7/20/15 21:05 == 44.5	7/21/15 1:40 == 26.5	7/21/15 6:15 == 45.6	7/21/15 10:50 == 46
7/20/15 21:10 == 44.6	7/21/15 1:45 == 26.4	7/21/15 6:20 == 45.7	7/21/15 10:55 == 46
7/20/15 21:15 == 44.4	7/21/15 1:50 == 26.3	7/21/15 6:25 == 45.8	7/21/15 11:00 == 46.3
7/20/15 21:20 == 44.5	7/21/15 1:55 == 26.4	7/21/15 6:30 == 45.7	7/21/15 11:05 == 46
7/20/15 21:25 == 44.5	7/21/15 2:00 == 26.4	7/21/15 6:35 == 45.7	7/21/15 11:10 == 46.3
7/20/15 21:30 == 44.5	7/21/15 2:05 == 26.4	7/21/15 6:40 == 45.8	7/21/15 11:15 == 46.2
7/20/15 21:35 == 44.5	7/21/15 2:10 == 26.4	7/21/15 6:45 == 46.6	7/21/15 11:20 == 45.9
7/20/15 21:40 == 44.5	7/21/15 2:15 == 26.4	7/21/15 6:50 == 46.4	7/21/15 11:25 == 46.2
7/20/15 21:45 == 44.6	7/21/15 2:20 == 26.4	7/21/15 6:55 == 46.2	7/21/15 11:30 == 45.9
7/20/15 21:50 == 44.5	7/21/15 2:25 == 26.4	7/21/15 7:00 == 46.2	7/21/15 11:35 == 45.8
7/20/15 21:55 == 44.5	7/21/15 2:30 == 26.4	7/21/15 7:05 == 46.2	7/21/15 11:40 == 46
7/20/15 22:00 == 44.6	7/21/15 2:35 == 26.4	7/21/15 7:10 == 46.4	7/21/15 11:45 == 46
7/20/15 22:05 == 44.6	7/21/15 2:40 == 26.4	7/21/15 7:15 == 46.1	7/21/15 11:50 == 46.5
7/20/15 22:10 == 44.3	7/21/15 2:45 == 26.5	7/21/15 7:20 == 46.1	7/21/15 11:55 == 45.8
7/20/15 22:15 == 44.5	7/21/15 2:50 == 26.4	7/21/15 7:25 == 46.4	7/21/15 12:00 == 46.1
7/20/15 22:20 == 44.7	7/21/15 2:55 == 26.4	7/21/15 7:30 == 46.2	7/21/15 12:05 == 45.9
7/20/15 22:25 == 44.6	7/21/15 3:00 == 26.5	7/21/15 7:35 == 46.4	7/21/15 12:10 == 46.1
7/20/15 22:30 == 44.6	7/21/15 3:05 == 26.4	7/21/15 7:40 == 46.4	7/21/15 12:15 == 46
7/20/15 22:35 == 44.6	7/21/15 3:10 == 26.5	7/21/15 7:45 == 46.2	7/21/15 12:20 == 45.8
7/20/15 22:40 == 44.6	7/21/15 3:15 == 26.3	7/21/15 7:50 == 46.3	7/21/15 12:25 == 46.1
7/20/15 22:45 == 44.6	7/21/15 3:20 == 26.4	7/21/15 7:55 == 46.3	7/21/15 12:30 == 45.9
7/20/15 22:50 == 44.5	7/21/15 3:25 == 26.4	7/21/15 8:00 == 46.1	7/21/15 12:35 == 46
7/20/15 22:55 == 44.6	7/21/15 3:30 == 26.5	7/21/15 8:05 == 46.2	7/21/15 12:40 == 46.2
7/20/15 23:00 == 44.6	7/21/15 3:35 == 26.4	7/21/15 8:10 == 46.4	7/21/15 12:45 == 46.3
7/20/15 23:05 == 44.4	7/21/15 3:40 == 26.5	7/21/15 8:15 == 46.2	7/21/15 12:50 == 46.4
7/20/15 23:10 == 42.3	7/21/15 3:45 == 26.5	7/21/15 8:20 == 46.2	7/21/15 12:55 == 46.6
7/20/15 23:15 == 31	7/21/15 3:50 == 26.4	7/21/15 8:25 == 46.5	7/21/15 13:00 == 46.5
7/20/15 23:20 == 31.1	7/21/15 3:55 == 26.5	7/21/15 8:30 == 46.1	7/21/15 13:05 == 46.5
7/20/15 23:25 == 31.3	7/21/15 4:00 == 26.5	7/21/15 8:35 == 46.2	7/21/15 13:10 == 46.7
7/20/15 23:30 == 31.7	7/21/15 4:05 == 26.5	7/21/15 8:40 == 46.1	7/21/15 13:15 == 46.7
7/20/15 23:35 == 31.8	7/21/15 4:10 == 26.5	7/21/15 8:45 == 46.1	7/21/15 13:20 == 46.5
7/20/15 23:40 == 31.8	7/21/15 4:15 == 26.5	7/21/15 8:50 == 46.2	7/21/15 13:25 == 46.4
7/20/15 23:45 == 32.2	7/21/15 4:20 == 26.4	7/21/15 8:55 == 46.2	7/21/15 13:30 == 46.5
7/20/15 23:50 == 32	7/21/15 4:25 == 26.5	7/21/15 9:00 == 46.1	7/21/15 13:35 == 46.7
7/20/15 23:55 == 31	7/21/15 4:30 == 26.5	7/21/15 9:05 == 46.4	7/21/15 13:40 == 46.5
7/21/15 0:00 == 26.4	7/21/15 4:35 == 26.5	7/21/15 9:10 == 46.4	7/21/15 13:45 == 46.4
7/21/15 0:05 == 26.4	7/21/15 4:40 == 26.4	7/21/15 9:15 == 46	7/21/15 13:50 == 46.6
7/21/15 0:10 == 26.3	7/21/15 4:45 == 26.4	7/21/15 9:20 == 46	7/21/15 13:55 == 46.7
7/21/15 0:15 == 26.3	7/21/15 4:50 == 26.5	7/21/15 9:25 == 46.1	7/21/15 14:00 == 46.4
7/21/15 0:20 == 26.3	7/21/15 4:55 == 26.5	7/21/15 9:30 == 46.2	7/21/15 14:05 == 46.3
7/21/15 0:25 == 26.4	7/21/15 5:00 == 26.6	7/21/15 9:35 == 46.1	7/21/15 14:10 == 46.4
7/21/15 0:30 == 26.3	7/21/15 5:05 == 36.5	7/21/15 9:40 == 46.1	7/21/15 14:15 == 46.5
7/21/15 0:35 == 26.3	7/21/15 5:10 == 45.3	7/21/15 9:45 == 46	7/21/15 14:20 == 46.6
7/21/15 0:40 == 26.3	7/21/15 5:15 == 45.2	7/21/15 9:50 == 46.5	7/21/15 14:25 == 46.4
7/21/15 0:45 == 26.4	7/21/15 5:20 == 45.5	7/21/15 9:55 == 45.8	7/21/15 14:30 == 46.6
7/21/15 0:50 == 26.3	7/21/15 5:25 == 44.9	7/21/15 10:00 == 46.3	7/21/15 14:35 == 46.3
7/21/15 0:55 == 26.3	7/21/15 5:30 == 45	7/21/15 10:05 == 39	7/21/15 14:40 == 46.4
7/21/15 1:00 == 26.4	7/21/15 5:35 == 44.9	7/21/15 10:10 == 32.6	7/21/15 14:45 == 46.3
7/21/15 1:05 == 26.4	7/21/15 5:40 == 44.9	7/21/15 10:15 == 32.8	7/21/15 14:50 == 46.4
7/21/15 1:10 == 26.4	7/21/15 5:45 == 44.9	7/21/15 10:20 == 34.2	7/21/15 14:55 == 46.4

Pumpback Station Discharge (0364)

7/21/15 15:00 == 46.2	7/21/15 19:35 == 45	7/22/15 0:10 == 44.9	7/22/15 4:45 == 44.9
7/21/15 15:05 == 46.1	7/21/15 19:40 == 44.9	7/22/15 0:15 == 45	7/22/15 4:50 == 45.1
7/21/15 15:10 == 46.4	7/21/15 19:45 == 44.9	7/22/15 0:20 == 45	7/22/15 4:55 == 45.1
7/21/15 15:15 == 46.2	7/21/15 19:50 == 45	7/22/15 0:25 == 45	7/22/15 5:00 == 45.1
7/21/15 15:20 == 45.8	7/21/15 19:55 == 44.9	7/22/15 0:30 == 45	7/22/15 5:05 == 44.9
7/21/15 15:25 == 45.3	7/21/15 20:00 == 45.1	7/22/15 0:35 == 45	7/22/15 5:10 == 45.1
7/21/15 15:30 == 45.5	7/21/15 20:05 == 44.8	7/22/15 0:40 == 45	7/22/15 5:15 == 45.2
7/21/15 15:35 == 45.1	7/21/15 20:10 == 44.9	7/22/15 0:45 == 44.9	7/22/15 5:20 == 45
7/21/15 15:40 == 45.4	7/21/15 20:15 == 44.9	7/22/15 0:50 == 45.1	7/22/15 5:25 == 45.2
7/21/15 15:45 == 45.2	7/21/15 20:20 == 45	7/22/15 0:55 == 44.9	7/22/15 5:30 == 45
7/21/15 15:50 == 45.9	7/21/15 20:25 == 45	7/22/15 1:00 == 45	7/22/15 5:35 == 45.3
7/21/15 15:55 == 45.6	7/21/15 20:30 == 44.8	7/22/15 1:05 == 44.8	7/22/15 5:40 == 45
7/21/15 16:00 == 46.2	7/21/15 20:35 == 45	7/22/15 1:10 == 44.9	7/22/15 5:45 == 45.1
7/21/15 16:05 == 45.9	7/21/15 20:40 == 45	7/22/15 1:15 == 44.9	7/22/15 5:50 == 45.2
7/21/15 16:10 == 45.8	7/21/15 20:45 == 44.9	7/22/15 1:20 == 45	7/22/15 5:55 == 44.8
7/21/15 16:15 == 45.9	7/21/15 20:50 == 45	7/22/15 1:25 == 45.2	7/22/15 6:00 == 45
7/21/15 16:20 == 45.2	7/21/15 20:55 == 45	7/22/15 1:30 == 44.9	7/22/15 6:05 == 45.7
7/21/15 16:25 == 44.9	7/21/15 21:00 == 44.9	7/22/15 1:35 == 44.9	7/22/15 6:10 == 45.8
7/21/15 16:30 == 45.1	7/21/15 21:05 == 44.9	7/22/15 1:40 == 45.1	7/22/15 6:15 == 45.8
7/21/15 16:35 == 45.2	7/21/15 21:10 == 44.8	7/22/15 1:45 == 45.1	7/22/15 6:20 == #
7/21/15 16:40 == 44.9	7/21/15 21:15 == 44.9	7/22/15 1:50 == 45	7/22/15 6:25 == 45.4
7/21/15 16:45 == 45	7/21/15 21:20 == 44.9	7/22/15 1:55 == 44.9	7/22/15 6:30 == 45.6
7/21/15 16:50 == 45	7/21/15 21:25 == 45.1	7/22/15 2:00 == 44.9	7/22/15 6:35 == 45.8
7/21/15 16:55 == 45	7/21/15 21:30 == 44.8	7/22/15 2:05 == 44.8	7/22/15 6:40 == 45.7
7/21/15 17:00 == 45	7/21/15 21:35 == 44.9	7/22/15 2:10 == 44.9	7/22/15 6:45 == 45.4
7/21/15 17:05 == 45	7/21/15 21:40 == 44.9	7/22/15 2:15 == 45	7/22/15 6:50 == 46
7/21/15 17:10 == 45	7/21/15 21:45 == 45	7/22/15 2:20 == 45	7/22/15 6:55 == 45.7
7/21/15 17:15 == 44.9	7/21/15 21:50 == 45	7/22/15 2:25 == 44.9	7/22/15 7:00 == 45.9
7/21/15 17:20 == 45	7/21/15 21:55 == 45	7/22/15 2:30 == 45	7/22/15 7:05 == 45.9
7/21/15 17:25 == 45	7/21/15 22:00 == 45.1	7/22/15 2:35 == 44.9	7/22/15 7:10 == 46
7/21/15 17:30 == 44.8	7/21/15 22:05 == 44.8	7/22/15 2:40 == 44.8	7/22/15 7:15 == 45.9
7/21/15 17:35 == 45.1	7/21/15 22:10 == 44.9	7/22/15 2:45 == 44.9	7/22/15 7:20 == 45.9
7/21/15 17:40 == 44.9	7/21/15 22:15 == 45	7/22/15 2:50 == 45	7/22/15 7:25 == 45
7/21/15 17:45 == 44.9	7/21/15 22:20 == 45	7/22/15 2:55 == 44.9	7/22/15 7:30 == 45.3
7/21/15 17:50 == 44.9	7/21/15 22:25 == 45	7/22/15 3:00 == 44.9	7/22/15 7:35 == 45.1
7/21/15 17:55 == 44.9	7/21/15 22:30 == 45.1	7/22/15 3:05 == 45	7/22/15 7:40 == 45.2
7/21/15 18:00 == 45	7/21/15 22:35 == 45	7/22/15 3:10 == 45	7/22/15 7:45 == 45.2
7/21/15 18:05 == 44.9	7/21/15 22:40 == 45	7/22/15 3:15 == 44.9	7/22/15 7:50 == 45.2
7/21/15 18:10 == 44.9	7/21/15 22:45 == 45.1	7/22/15 3:20 == 44.9	7/22/15 7:55 == 45.1
7/21/15 18:15 == 44.8	7/21/15 22:50 == 45.1	7/22/15 3:25 == 45.1	7/22/15 8:00 == 45.1
7/21/15 18:20 == 45	7/21/15 22:55 == 45	7/22/15 3:30 == 44.9	7/22/15 8:05 == 45.6
7/21/15 18:25 == 44.9	7/21/15 23:00 == 45.1	7/22/15 3:35 == 44.9	7/22/15 8:10 == 45
7/21/15 18:30 == 44.9	7/21/15 23:05 == 44.9	7/22/15 3:40 == 44.8	7/22/15 8:15 == 45.3
7/21/15 18:35 == 45.1	7/21/15 23:10 == 45	7/22/15 3:45 == 45	7/22/15 8:20 == 45.9
7/21/15 18:40 == 44.9	7/21/15 23:15 == 45	7/22/15 3:50 == 45	7/22/15 8:25 == 46.2
7/21/15 18:45 == 45	7/21/15 23:20 == 45	7/22/15 3:55 == 44.9	7/22/15 8:30 == 46
7/21/15 18:50 == 45	7/21/15 23:25 == 45.1	7/22/15 4:00 == 45	7/22/15 8:35 == 45.8
7/21/15 18:55 == 45	7/21/15 23:30 == 45	7/22/15 4:05 == 44.9	7/22/15 8:40 == 46.4
7/21/15 19:00 == 44.9	7/21/15 23:35 == 45	7/22/15 4:10 == 45	7/22/15 8:45 == 45.9
7/21/15 19:05 == 44.9	7/21/15 23:40 == 44.9	7/22/15 4:15 == 45.1	7/22/15 8:50 == 46
7/21/15 19:10 == 44.9	7/21/15 23:45 == 45	7/22/15 4:20 == 44.9	7/22/15 8:55 == 46.1
7/21/15 19:15 == 45	7/21/15 23:50 == 44.9	7/22/15 4:25 == 44.9	7/22/15 9:00 == 45.2
7/21/15 19:20 == 44.9	7/21/15 23:55 == 45	7/22/15 4:30 == 44.9	7/22/15 9:05 == 45.8
7/21/15 19:25 == 45.1	7/22/15 0:00 == 45.1	7/22/15 4:35 == 44.9	7/22/15 9:10 == 45.6
7/21/15 19:30 == 44.8	7/22/15 0:05 == 45	7/22/15 4:40 == 45.1	7/22/15 9:15 == 45.5

Pumpback Station Discharge (0364)

7/22/15 9:20 == 45.6	7/22/15 13:55 == 46.6	7/22/15 18:30 == 45	7/22/15 23:05 == 45
7/22/15 9:25 == 45.6	7/22/15 14:00 == 46.4	7/22/15 18:35 == 44.8	7/22/15 23:10 == 45.1
7/22/15 9:30 == 45.7	7/22/15 14:05 == 46.5	7/22/15 18:40 == 45	7/22/15 23:15 == 44.9
7/22/15 9:35 == 45.4	7/22/15 14:10 == 46.9	7/22/15 18:45 == 44.8	7/22/15 23:20 == 44.9
7/22/15 9:40 == 46.1	7/22/15 14:15 == 46.8	7/22/15 18:50 == 44.9	7/22/15 23:25 == 44.9
7/22/15 9:45 == 45.5	7/22/15 14:20 == 46.7	7/22/15 18:55 == 45.1	7/22/15 23:30 == 45
7/22/15 9:50 == 45.6	7/22/15 14:25 == 47	7/22/15 19:00 == 44.9	7/22/15 23:35 == 45
7/22/15 9:55 == 45.7	7/22/15 14:30 == 46.6	7/22/15 19:05 == 45	7/22/15 23:40 == 44.9
7/22/15 10:00 == 45.5	7/22/15 14:35 == 46.3	7/22/15 19:10 == 45	7/22/15 23:45 == 45
7/22/15 10:05 == 45.5	7/22/15 14:40 == 46.1	7/22/15 19:15 == 44.9	7/22/15 23:50 == 44.9
7/22/15 10:10 == 45.6	7/22/15 14:45 == 46.3	7/22/15 19:20 == 45	7/22/15 23:55 == 44.9
7/22/15 10:15 == 45.2	7/22/15 14:50 == 46.1	7/22/15 19:25 == 44.9	7/23/15 0:00 == 44.9
7/22/15 10:20 == 45.8	7/22/15 14:55 == 46.5	7/22/15 19:30 == 45.1	7/23/15 0:05 == 45
7/22/15 10:25 == 45.3	7/22/15 15:00 == 45.7	7/22/15 19:35 == 45	7/23/15 0:10 == 44.8
7/22/15 10:30 == 45.9	7/22/15 15:05 == 46.1	7/22/15 19:40 == 44.9	7/23/15 0:15 == 44.9
7/22/15 10:35 == 46.2	7/22/15 15:10 == 45.9	7/22/15 19:45 == 45	7/23/15 0:20 == 44.9
7/22/15 10:40 == 46.2	7/22/15 15:15 == 45.9	7/22/15 19:50 == 44.9	7/23/15 0:25 == 44.9
7/22/15 10:45 == 45.9	7/22/15 15:20 == 45.7	7/22/15 19:55 == 45	7/23/15 0:30 == 45
7/22/15 10:50 == 46.4	7/22/15 15:25 == 45.8	7/22/15 20:00 == 44.9	7/23/15 0:35 == 45
7/22/15 10:55 == 46.7	7/22/15 15:30 == 45.3	7/22/15 20:05 == 44.9	7/23/15 0:40 == 44.9
7/22/15 11:00 == 46.3	7/22/15 15:35 == 45.7	7/22/15 20:10 == 44.9	7/23/15 0:45 == 44.9
7/22/15 11:05 == 46.3	7/22/15 15:40 == 45.9	7/22/15 20:15 == 45	7/23/15 0:50 == 44.9
7/22/15 11:10 == 46.3	7/22/15 15:45 == 46.1	7/22/15 20:20 == 45	7/23/15 0:55 == 44.9
7/22/15 11:15 == 46.5	7/22/15 15:50 == 46.1	7/22/15 20:25 == 45	7/23/15 1:00 == 45
7/22/15 11:20 == 46.4	7/22/15 15:55 == 46.1	7/22/15 20:30 == 45	7/23/15 1:05 == 45
7/22/15 11:25 == 45.5	7/22/15 16:00 == 45.8	7/22/15 20:35 == 44.9	7/23/15 1:10 == 45.1
7/22/15 11:30 == 45.2	7/22/15 16:05 == 45.9	7/22/15 20:40 == 45	7/23/15 1:15 == 44.8
7/22/15 11:35 == 45.2	7/22/15 16:10 == 45.4	7/22/15 20:45 == 44.8	7/23/15 1:20 == 44.9
7/22/15 11:40 == 45.9	7/22/15 16:15 == 45.5	7/22/15 20:50 == 44.8	7/23/15 1:25 == 45
7/22/15 11:45 == 45.5	7/22/15 16:20 == 45.7	7/22/15 20:55 == 44.9	7/23/15 1:30 == 44.9
7/22/15 11:50 == 46	7/22/15 16:25 == 45.8	7/22/15 21:00 == 45	7/23/15 1:35 == 44.9
7/22/15 11:55 == 45.6	7/22/15 16:30 == 45.3	7/22/15 21:05 == 44.8	7/23/15 1:40 == 44.9
7/22/15 12:00 == 45.8	7/22/15 16:35 == 45.6	7/22/15 21:10 == 45	7/23/15 1:45 == 45
7/22/15 12:05 == 45.6	7/22/15 16:40 == 45.4	7/22/15 21:15 == 44.8	7/23/15 1:50 == 44.8
7/22/15 12:10 == 45.9	7/22/15 16:45 == 45.5	7/22/15 21:20 == 44.9	7/23/15 1:55 == 45
7/22/15 12:15 == 45.6	7/22/15 16:50 == 45.4	7/22/15 21:25 == 44.7	7/23/15 2:00 == 45
7/22/15 12:20 == 45.8	7/22/15 16:55 == 45.5	7/22/15 21:30 == 44.9	7/23/15 2:05 == 45
7/22/15 12:25 == 45.6	7/22/15 17:00 == 45.4	7/22/15 21:35 == 45	7/23/15 2:10 == 44.8
7/22/15 12:30 == 45.6	7/22/15 17:05 == 44.9	7/22/15 21:40 == 44.9	7/23/15 2:15 == 44.9
7/22/15 12:35 == 45.3	7/22/15 17:10 == 45.1	7/22/15 21:45 == 45.1	7/23/15 2:20 == 44.9
7/22/15 12:40 == 45.8	7/22/15 17:15 == 44.9	7/22/15 21:50 == 44.8	7/23/15 2:25 == 44.9
7/22/15 12:45 == 45.5	7/22/15 17:20 == 45	7/22/15 21:55 == 45	7/23/15 2:30 == 44.9
7/22/15 12:50 == 45.5	7/22/15 17:25 == 45	7/22/15 22:00 == 44.9	7/23/15 2:35 == 45
7/22/15 12:55 == 45.7	7/22/15 17:30 == 44.9	7/22/15 22:05 == 45	7/23/15 2:40 == 44.8
7/22/15 13:00 == 45.4	7/22/15 17:35 == 45	7/22/15 22:10 == 44.8	7/23/15 2:45 == 45
7/22/15 13:05 == 46.2	7/22/15 17:40 == 44.9	7/22/15 22:15 == 44.9	7/23/15 2:50 == 44.9
7/22/15 13:10 == 46.1	7/22/15 17:45 == 45.1	7/22/15 22:20 == 45.1	7/23/15 2:55 == 45
7/22/15 13:15 == 46.2	7/22/15 17:50 == 44.9	7/22/15 22:25 == 45	7/23/15 3:00 == 45
7/22/15 13:20 == 46.4	7/22/15 17:55 == 44.9	7/22/15 22:30 == 44.9	7/23/15 3:05 == 44.8
7/22/15 13:25 == 46.2	7/22/15 18:00 == 45	7/22/15 22:35 == 45.2	7/23/15 3:10 == 45
7/22/15 13:30 == 46.1	7/22/15 18:05 == 45	7/22/15 22:40 == 45	7/23/15 3:15 == 44.8
7/22/15 13:35 == 46.1	7/22/15 18:10 == 44.9	7/22/15 22:45 == 44.9	7/23/15 3:20 == 45
7/22/15 13:40 == 45.9	7/22/15 18:15 == 44.9	7/22/15 22:50 == 45	7/23/15 3:25 == 45
7/22/15 13:45 == 46.2	7/22/15 18:20 == 45.1	7/22/15 22:55 == 45	7/23/15 3:30 == 45
7/22/15 13:50 == 46.2	7/22/15 18:25 == 44.9	7/22/15 23:00 == 45.1	7/23/15 3:35 == 44.9

Pumpback Station Discharge (0364)

7/23/15 3:40 == 44.9	7/23/15 8:15 == 45.1	7/23/15 12:50 == 45.2	7/23/15 17:25 == 45.1
7/23/15 3:45 == 45.1	7/23/15 8:20 == 45.1	7/23/15 12:55 == 45	7/23/15 17:30 == 45.1
7/23/15 3:50 == 45	7/23/15 8:25 == 45	7/23/15 13:00 == 45.2	7/23/15 17:35 == 45.2
7/23/15 3:55 == 45	7/23/15 8:30 == 45.4	7/23/15 13:05 == 45.5	7/23/15 17:40 == 45.1
7/23/15 4:00 == 45	7/23/15 8:35 == 45.1	7/23/15 13:10 == 45.3	7/23/15 17:45 == 45.2
7/23/15 4:05 == 45.1	7/23/15 8:40 == 45.5	7/23/15 13:15 == 45.2	7/23/15 17:50 == 45.1
7/23/15 4:10 == 45	7/23/15 8:45 == 45.5	7/23/15 13:20 == 45.5	7/23/15 17:55 == 45.2
7/23/15 4:15 == 44.9	7/23/15 8:50 == 44.8	7/23/15 13:25 == 45.1	7/23/15 18:00 == 45.1
7/23/15 4:20 == 44.9	7/23/15 8:55 == 45.2	7/23/15 13:30 == 45.2	7/23/15 18:05 == 45.1
7/23/15 4:25 == 45	7/23/15 9:00 == 45.2	7/23/15 13:35 == 45.1	7/23/15 18:10 == 45.2
7/23/15 4:30 == 45	7/23/15 9:05 == 46	7/23/15 13:40 == 45.2	7/23/15 18:15 == 45.2
7/23/15 4:35 == 45.1	7/23/15 9:10 == 46	7/23/15 13:45 == 45.4	7/23/15 18:20 == 45.2
7/23/15 4:40 == 44.9	7/23/15 9:15 == 45.9	7/23/15 13:50 == 45.3	7/23/15 18:25 == 45.1
7/23/15 4:45 == 45.4	7/23/15 9:20 == 46	7/23/15 13:55 == 46.1	7/23/15 18:30 == 45.2
7/23/15 4:50 == 44.9	7/23/15 9:25 == 45.8	7/23/15 14:00 == 46	7/23/15 18:35 == 45.2
7/23/15 4:55 == 45	7/23/15 9:30 == 46.1	7/23/15 14:05 == 46	7/23/15 18:40 == 45.2
7/23/15 5:00 == 45.4	7/23/15 9:35 == 45.9	7/23/15 14:10 == 45.9	7/23/15 18:45 == 45.1
7/23/15 5:05 == 44.9	7/23/15 9:40 == 46	7/23/15 14:15 == 46.3	7/23/15 18:50 == 45
7/23/15 5:10 == 45.1	7/23/15 9:45 == 46	7/23/15 14:20 == 45.8	7/23/15 18:55 == 45.1
7/23/15 5:15 == 45.1	7/23/15 9:50 == 46	7/23/15 14:25 == 46	7/23/15 19:00 == 45.3
7/23/15 5:20 == 45.3	7/23/15 9:55 == 45.9	7/23/15 14:30 == 46.1	7/23/15 19:05 == 45.1
7/23/15 5:25 == 45.2	7/23/15 10:00 == 46	7/23/15 14:35 == 46.3	7/23/15 19:10 == 45.1
7/23/15 5:30 == 45	7/23/15 10:05 == 45.1	7/23/15 14:40 == 45.8	7/23/15 19:15 == 45.1
7/23/15 5:35 == 45.2	7/23/15 10:10 == 45.4	7/23/15 14:45 == 45.4	7/23/15 19:20 == 45
7/23/15 5:40 == 45.3	7/23/15 10:15 == 45.1	7/23/15 14:50 == 45.3	7/23/15 19:25 == 45.1
7/23/15 5:45 == 45.1	7/23/15 10:20 == 45.1	7/23/15 14:55 == 45.2	7/23/15 19:30 == 45.1
7/23/15 5:50 == 45.1	7/23/15 10:25 == 45.5	7/23/15 15:00 == 45.2	7/23/15 19:35 == 45.2
7/23/15 5:55 == 45	7/23/15 10:30 == 45.1	7/23/15 15:05 == 45.2	7/23/15 19:40 == 45.2
7/23/15 6:00 == 45	7/23/15 10:35 == 45.2	7/23/15 15:10 == 45.4	7/23/15 19:45 == 45
7/23/15 6:05 == 45.1	7/23/15 10:40 == 45	7/23/15 15:15 == 45.3	7/23/15 19:50 == 45.1
7/23/15 6:10 == 45.1	7/23/15 10:45 == 45.6	7/23/15 15:20 == 45.2	7/23/15 19:55 == 45.1
7/23/15 6:15 == 45.4	7/23/15 10:50 == 45.2	7/23/15 15:25 == 45.5	7/23/15 20:00 == 45.1
7/23/15 6:20 == 45.2	7/23/15 10:55 == 45.1	7/23/15 15:30 == 45.7	7/23/15 20:05 == 45.2
7/23/15 6:25 == 45.2	7/23/15 11:00 == 45.1	7/23/15 15:35 == 45	7/23/15 20:10 == 45.1
7/23/15 6:30 == 45.2	7/23/15 11:05 == 45.2	7/23/15 15:40 == 45.2	7/23/15 20:15 == 45.1
7/23/15 6:35 == 45.1	7/23/15 11:10 == 45.5	7/23/15 15:45 == 45.4	7/23/15 20:20 == 45.1
7/23/15 6:40 == 45.3	7/23/15 11:15 == 44.9	7/23/15 15:50 == 45.3	7/23/15 20:25 == 45.1
7/23/15 6:45 == 45.3	7/23/15 11:20 == 45.2	7/23/15 15:55 == 45.2	7/23/15 20:30 == 45.1
7/23/15 6:50 == 45.3	7/23/15 11:25 == 45.5	7/23/15 16:00 == 45.2	7/23/15 20:35 == 45.1
7/23/15 6:55 == 45.5	7/23/15 11:30 == 45.3	7/23/15 16:05 == 45.5	7/23/15 20:40 == 45.1
7/23/15 7:00 == 45.5	7/23/15 11:35 == 44.9	7/23/15 16:10 == 45	7/23/15 20:45 == 45.2
7/23/15 7:05 == 45.2	7/23/15 11:40 == 45	7/23/15 16:15 == 45.4	7/23/15 20:50 == 45
7/23/15 7:10 == 45.5	7/23/15 11:45 == 45.4	7/23/15 16:20 == 45.1	7/23/15 20:55 == 45.2
7/23/15 7:15 == 45.3	7/23/15 11:50 == 45.9	7/23/15 16:25 == 45.2	7/23/15 21:00 == 45.1
7/23/15 7:20 == 45.7	7/23/15 11:55 == 45.9	7/23/15 16:30 == 45.1	7/23/15 21:05 == 45.2
7/23/15 7:25 == 45.2	7/23/15 12:00 == 45.9	7/23/15 16:35 == 45.3	7/23/15 21:10 == 45.1
7/23/15 7:30 == 45.5	7/23/15 12:05 == 46.3	7/23/15 16:40 == 45.2	7/23/15 21:15 == 45.2
7/23/15 7:35 == 45.4	7/23/15 12:10 == 46	7/23/15 16:45 == 45.1	7/23/15 21:20 == 45.1
7/23/15 7:40 == 45.4	7/23/15 12:15 == 45.8	7/23/15 16:50 == 45.1	7/23/15 21:25 == 45.1
7/23/15 7:45 == 45.5	7/23/15 12:20 == 46.1	7/23/15 16:55 == 45	7/23/15 21:30 == 45.1
7/23/15 7:50 == 45.2	7/23/15 12:25 == 45.8	7/23/15 17:00 == 45.1	7/23/15 21:35 == 45.2
7/23/15 7:55 == 45	7/23/15 12:30 == 45.9	7/23/15 17:05 == 45.1	7/23/15 21:40 == 45.3
7/23/15 8:00 == 45.2	7/23/15 12:35 == 45.8	7/23/15 17:10 == 45.2	7/23/15 21:45 == 45.1
7/23/15 8:05 == 45.1	7/23/15 12:40 == 45	7/23/15 17:15 == 45.1	7/23/15 21:50 == 45.1
7/23/15 8:10 == 45	7/23/15 12:45 == 45.3	7/23/15 17:20 == 45.2	7/23/15 21:55 == 45.2

Pumpback Station Discharge (0364)

7/23/15 22:00 == 45.1	7/24/15 2:35 == 45.2	7/24/15 7:10 == 45.7	7/24/15 11:45 == 45.8
7/23/15 22:05 == 45.2	7/24/15 2:40 == 45.1	7/24/15 7:15 == 45.6	7/24/15 11:50 == 45.6
7/23/15 22:10 == 45.3	7/24/15 2:45 == 45.3	7/24/15 7:20 == 45.7	7/24/15 11:55 == 45.9
7/23/15 22:15 == 45.1	7/24/15 2:50 == 45.2	7/24/15 7:25 == 45.5	7/24/15 12:00 == 45.7
7/23/15 22:20 == 45.2	7/24/15 2:55 == 45.2	7/24/15 7:30 == 45.4	7/24/15 12:05 == 45.7
7/23/15 22:25 == 45.2	7/24/15 3:00 == 45.1	7/24/15 7:35 == 45.6	7/24/15 12:10 == 45.5
7/23/15 22:30 == 45.2	7/24/15 3:05 == 45.2	7/24/15 7:40 == 45.5	7/24/15 12:15 == 45.9
7/23/15 22:35 == 45.2	7/24/15 3:10 == 45.2	7/24/15 7:45 == 45.3	7/24/15 12:20 == 45.3
7/23/15 22:40 == 45.1	7/24/15 3:15 == 45.1	7/24/15 7:50 == 45.6	7/24/15 12:25 == 45.5
7/23/15 22:45 == 45.2	7/24/15 3:20 == 45.2	7/24/15 7:55 == 45.9	7/24/15 12:30 == 45.6
7/23/15 22:50 == 45.2	7/24/15 3:25 == 45.2	7/24/15 8:00 == 45.5	7/24/15 12:35 == 45.4
7/23/15 22:55 == 45.1	7/24/15 3:30 == 45.3	7/24/15 8:05 == 45.6	7/24/15 12:40 == 46
7/23/15 23:00 == 45.1	7/24/15 3:35 == 45.1	7/24/15 8:10 == 45.5	7/24/15 12:45 == 45
7/23/15 23:05 == 45.2	7/24/15 3:40 == 45.1	7/24/15 8:15 == 45.8	7/24/15 12:50 == 45.3
7/23/15 23:10 == 45.1	7/24/15 3:45 == 45.2	7/24/15 8:20 == 45.6	7/24/15 12:55 == 45.5
7/23/15 23:15 == 45.1	7/24/15 3:50 == 45.2	7/24/15 8:25 == 45.5	7/24/15 13:00 == 45.3
7/23/15 23:20 == 45.2	7/24/15 3:55 == 45.2	7/24/15 8:30 == 45.5	7/24/15 13:05 == 45.7
7/23/15 23:25 == 45.1	7/24/15 4:00 == 45.3	7/24/15 8:35 == 45.6	7/24/15 13:10 == 45.3
7/23/15 23:30 == 45	7/24/15 4:05 == 45.2	7/24/15 8:40 == 45.5	7/24/15 13:15 == 45.5
7/23/15 23:35 == 45.2	7/24/15 4:10 == 45.2	7/24/15 8:45 == 46.2	7/24/15 13:20 == 45.7
7/23/15 23:40 == 45.1	7/24/15 4:15 == 45.1	7/24/15 8:50 == 45.8	7/24/15 13:25 == 45.5
7/23/15 23:45 == 45.2	7/24/15 4:20 == 45.1	7/24/15 8:55 == 45.4	7/24/15 13:30 == 45.4
7/23/15 23:50 == 45.3	7/24/15 4:25 == 45.2	7/24/15 9:00 == 45.8	7/24/15 13:35 == 45.4
7/23/15 23:55 == 45.1	7/24/15 4:30 == 45.2	7/24/15 9:05 == 45.5	7/24/15 13:40 == 45.4
7/24/15 0:00 == 45.2	7/24/15 4:35 == 45.2	7/24/15 9:10 == 45.8	7/24/15 13:45 == 45.5
7/24/15 0:05 == 45.1	7/24/15 4:40 == 45.5	7/24/15 9:15 == 45.6	7/24/15 13:50 == 45.8
7/24/15 0:10 == 45.2	7/24/15 4:45 == 45.1	7/24/15 9:20 == 46	7/24/15 13:55 == 45.6
7/24/15 0:15 == 45.2	7/24/15 4:50 == 45.1	7/24/15 9:25 == 46.1	7/24/15 14:00 == 45.6
7/24/15 0:20 == 45.2	7/24/15 4:55 == 45.2	7/24/15 9:30 == 45.7	7/24/15 14:05 == 45.4
7/24/15 0:25 == 45.2	7/24/15 5:00 == 45.4	7/24/15 9:35 == 45.7	7/24/15 14:10 == 45.4
7/24/15 0:30 == 45.1	7/24/15 5:05 == 45.3	7/24/15 9:40 == 45.9	7/24/15 14:15 == 45.5
7/24/15 0:35 == 45.2	7/24/15 5:10 == 45.1	7/24/15 9:45 == 45.7	7/24/15 14:20 == 45.5
7/24/15 0:40 == 45.2	7/24/15 5:15 == 45.6	7/24/15 9:50 == 45.7	7/24/15 14:25 == 45.2
7/24/15 0:45 == 45.2	7/24/15 5:20 == 45.4	7/24/15 9:55 == 45.6	7/24/15 14:30 == 46.3
7/24/15 0:50 == 45.3	7/24/15 5:25 == 45.4	7/24/15 10:00 == 45.6	7/24/15 14:35 == 45.6
7/24/15 0:55 == 45.2	7/24/15 5:30 == 45.2	7/24/15 10:05 == 45.6	7/24/15 14:40 == 45.8
7/24/15 1:00 == 45.2	7/24/15 5:35 == 45.1	7/24/15 10:10 == 45.8	7/24/15 14:45 == 45.4
7/24/15 1:05 == 45.2	7/24/15 5:40 == 45.2	7/24/15 10:15 == 45.8	7/24/15 14:50 == 45.6
7/24/15 1:10 == 45.1	7/24/15 5:45 == 45.3	7/24/15 10:20 == 45.4	7/24/15 14:55 == 45.6
7/24/15 1:15 == 45.2	7/24/15 5:50 == 45.3	7/24/15 10:25 == 45.7	7/24/15 15:00 == 45.7
7/24/15 1:20 == 45.2	7/24/15 5:55 == 45.3	7/24/15 10:30 == 45.9	7/24/15 15:05 == 46
7/24/15 1:25 == 45.1	7/24/15 6:00 == 45.2	7/24/15 10:35 == 45.5	7/24/15 15:10 == 45.6
7/24/15 1:30 == 45.2	7/24/15 6:05 == 45.5	7/24/15 10:40 == 45.3	7/24/15 15:15 == 46
7/24/15 1:35 == 45.1	7/24/15 6:10 == 45.1	7/24/15 10:45 == 45.4	7/24/15 15:20 == 45.5
7/24/15 1:40 == 45.2	7/24/15 6:15 == 45.4	7/24/15 10:50 == 45.5	7/24/15 15:25 == 45.5
7/24/15 1:45 == 45.2	7/24/15 6:20 == 45.2	7/24/15 10:55 == 45.6	7/24/15 15:30 == 45.8
7/24/15 1:50 == 45.1	7/24/15 6:25 == 45.3	7/24/15 11:00 == 45.5	7/24/15 15:35 == 46
7/24/15 1:55 == 45.1	7/24/15 6:30 == 45.5	7/24/15 11:05 == 45.7	7/24/15 15:40 == 45.9
7/24/15 2:00 == 45.1	7/24/15 6:35 == 45.5	7/24/15 11:10 == 45.7	7/24/15 15:45 == 45.7
7/24/15 2:05 == 45.2	7/24/15 6:40 == 45.1	7/24/15 11:15 == 45.5	7/24/15 15:50 == 45.8
7/24/15 2:10 == 45.2	7/24/15 6:45 == 45.1	7/24/15 11:20 == 45.7	7/24/15 15:55 == 45.6
7/24/15 2:15 == 45.3	7/24/15 6:50 == 46	7/24/15 11:25 == 45.7	7/24/15 16:00 == 45.5
7/24/15 2:20 == 45.2	7/24/15 6:55 == 45.6	7/24/15 11:30 == 45.4	7/24/15 16:05 == 45.6
7/24/15 2:25 == 45.2	7/24/15 7:00 == 45.5	7/24/15 11:35 == 45.4	7/24/15 16:10 == 45.7
7/24/15 2:30 == 45.2	7/24/15 7:05 == 45.6	7/24/15 11:40 == 45.8	7/24/15 16:15 == 45.4

Pumpback Station Discharge (0364)

7/24/15 16:20 == 45.5	7/24/15 20:55 == 45.2	7/25/15 1:30 == 45.2	7/25/15 6:05 == 45.5
7/24/15 16:25 == 45.1	7/24/15 21:00 == 45	7/25/15 1:35 == 45.2	7/25/15 6:10 == 45.5
7/24/15 16:30 == 45.2	7/24/15 21:05 == 45.3	7/25/15 1:40 == 45.1	7/25/15 6:15 == 45.2
7/24/15 16:35 == 45.3	7/24/15 21:10 == 45.1	7/25/15 1:45 == 45.2	7/25/15 6:20 == 45.4
7/24/15 16:40 == 45.1	7/24/15 21:15 == 45.1	7/25/15 1:50 == 45.2	7/25/15 6:25 == 45.1
7/24/15 16:45 == 45.1	7/24/15 21:20 == 45.2	7/25/15 1:55 == 45.1	7/25/15 6:30 == 45.2
7/24/15 16:50 == 45.1	7/24/15 21:25 == 45.1	7/25/15 2:00 == 45.2	7/25/15 6:35 == 45.2
7/24/15 16:55 == 45.1	7/24/15 21:30 == 45.2	7/25/15 2:05 == 45.2	7/25/15 6:40 == 45.2
7/24/15 17:00 == 45.1	7/24/15 21:35 == 45.1	7/25/15 2:10 == 45.1	7/25/15 6:45 == 45.3
7/24/15 17:05 == 45.1	7/24/15 21:40 == 45.1	7/25/15 2:15 == 45.2	7/25/15 6:50 == 45.2
7/24/15 17:10 == 45.1	7/24/15 21:45 == 45.1	7/25/15 2:20 == 45.1	7/25/15 6:55 == 45.4
7/24/15 17:15 == 45.1	7/24/15 21:50 == 45.2	7/25/15 2:25 == 45.1	7/25/15 7:00 == 45.4
7/24/15 17:20 == 45.1	7/24/15 21:55 == 45.2	7/25/15 2:30 == 45.2	7/25/15 7:05 == 45.5
7/24/15 17:25 == 45.2	7/24/15 22:00 == 45.1	7/25/15 2:35 == 45.2	7/25/15 7:10 == 45.4
7/24/15 17:30 == 45.1	7/24/15 22:05 == 45.2	7/25/15 2:40 == 45.1	7/25/15 7:15 == 45.2
7/24/15 17:35 == 45.1	7/24/15 22:10 == 45.3	7/25/15 2:45 == 45.1	7/25/15 7:20 == 45.1
7/24/15 17:40 == 45.1	7/24/15 22:15 == 45.2	7/25/15 2:50 == 45.1	7/25/15 7:25 == 45.1
7/24/15 17:45 == 45.1	7/24/15 22:20 == 45.2	7/25/15 2:55 == 45.1	7/25/15 7:30 == 45.2
7/24/15 17:50 == 45.1	7/24/15 22:25 == 45.3	7/25/15 3:00 == 45.1	7/25/15 7:35 == 45.2
7/24/15 17:55 == 45.2	7/24/15 22:30 == 45.3	7/25/15 3:05 == 45.1	7/25/15 7:40 == 45.1
7/24/15 18:00 == 45.2	7/24/15 22:35 == 45.2	7/25/15 3:10 == 45.1	7/25/15 7:45 == 45.2
7/24/15 18:05 == 45.2	7/24/15 22:40 == 45.2	7/25/15 3:15 == 45.2	7/25/15 7:50 == 45.2
7/24/15 18:10 == 45.2	7/24/15 22:45 == 45	7/25/15 3:20 == 45.2	7/25/15 7:55 == 45.2
7/24/15 18:15 == 45.1	7/24/15 22:50 == 45.1	7/25/15 3:25 == 45.2	7/25/15 8:00 == 45.1
7/24/15 18:20 == 45.2	7/24/15 22:55 == 45.2	7/25/15 3:30 == 45	7/25/15 8:05 == 45.1
7/24/15 18:25 == 45.1	7/24/15 23:00 == 45.1	7/25/15 3:35 == 45.1	7/25/15 8:10 == 45.3
7/24/15 18:30 == 45.2	7/24/15 23:05 == 45.1	7/25/15 3:40 == 45.2	7/25/15 8:15 == 45.2
7/24/15 18:35 == 45.1	7/24/15 23:10 == 45.2	7/25/15 3:45 == 45.2	7/25/15 8:20 == 45.2
7/24/15 18:40 == 45	7/24/15 23:15 == 45.2	7/25/15 3:50 == 45.1	7/25/15 8:25 == 45.1
7/24/15 18:45 == 45.1	7/24/15 23:20 == 45.2	7/25/15 3:55 == 45.1	7/25/15 8:30 == 45.2
7/24/15 18:50 == 45.1	7/24/15 23:25 == 45.1	7/25/15 4:00 == 45.2	7/25/15 8:35 == 45.7
7/24/15 18:55 == 45	7/24/15 23:30 == 45.2	7/25/15 4:05 == 45.2	7/25/15 8:40 == 45.3
7/24/15 19:00 == 45.1	7/24/15 23:35 == 45.2	7/25/15 4:10 == 45.2	7/25/15 8:45 == 45.5
7/24/15 19:05 == 45.2	7/24/15 23:40 == 45.2	7/25/15 4:15 == 45.1	7/25/15 8:50 == 45.3
7/24/15 19:10 == #	7/24/15 23:45 == 45.2	7/25/15 4:20 == 45.1	7/25/15 8:55 == 45.1
7/24/15 19:15 == 45.2	7/24/15 23:50 == 45.2	7/25/15 4:25 == 45.1	7/25/15 9:00 == 45.4
7/24/15 19:20 == 45.2	7/24/15 23:55 == 45.3	7/25/15 4:30 == 45.2	7/25/15 9:05 == 45.4
7/24/15 19:25 == 45.2	7/25/15 0:00 == 45.1	7/25/15 4:35 == 45.1	7/25/15 9:10 == 45.3
7/24/15 19:30 == 45.2	7/25/15 0:05 == 45.2	7/25/15 4:40 == 45.2	7/25/15 9:15 == 45.2
7/24/15 19:35 == 45.2	7/25/15 0:10 == 45.3	7/25/15 4:45 == 45.2	7/25/15 9:20 == 45.3
7/24/15 19:40 == 45.2	7/25/15 0:15 == 45.2	7/25/15 4:50 == 45.2	7/25/15 9:25 == 45.3
7/24/15 19:45 == 45.1	7/25/15 0:20 == 45.1	7/25/15 4:55 == 45.1	7/25/15 9:30 == 45.5
7/24/15 19:50 == 45.2	7/25/15 0:25 == 45.1	7/25/15 5:00 == 45.4	7/25/15 9:35 == 45.3
7/24/15 19:55 == 45.2	7/25/15 0:30 == 45.2	7/25/15 5:05 == 45.4	7/25/15 9:40 == 45.3
7/24/15 20:00 == 45.1	7/25/15 0:35 == 45.2	7/25/15 5:10 == 45.2	7/25/15 9:45 == 45.5
7/24/15 20:05 == 45.1	7/25/15 0:40 == 45.2	7/25/15 5:15 == 45.2	7/25/15 9:50 == 45.6
7/24/15 20:10 == 45.2	7/25/15 0:45 == 45.2	7/25/15 5:20 == 45.4	7/25/15 9:55 == 45.2
7/24/15 20:15 == 45.2	7/25/15 0:50 == 45.2	7/25/15 5:25 == 45.2	7/25/15 10:00 == 45.6
7/24/15 20:20 == 45.1	7/25/15 0:55 == 45.2	7/25/15 5:30 == 45.1	7/25/15 10:05 == 45
7/24/15 20:25 == 45.1	7/25/15 1:00 == 45.1	7/25/15 5:35 == 45.2	7/25/15 10:10 == 45.1
7/24/15 20:30 == 45.2	7/25/15 1:05 == 45.2	7/25/15 5:40 == 45.1	7/25/15 10:15 == 45.1
7/24/15 20:35 == 45	7/25/15 1:10 == 45.2	7/25/15 5:45 == 45.4	7/25/15 10:20 == 45.2
7/24/15 20:40 == 45.1	7/25/15 1:15 == 45.1	7/25/15 5:50 == 45.3	7/25/15 10:25 == 45.4
7/24/15 20:45 == 45.2	7/25/15 1:20 == 45.2	7/25/15 5:55 == 45.2	7/25/15 10:30 == 45.4
7/24/15 20:50 == 45.1	7/25/15 1:25 == 45.1	7/25/15 6:00 == 45.2	7/25/15 10:35 == 45.2

Pumpback Station Discharge (0364)

7/25/15 10:40 == 45.2	7/25/15 15:15 == 44.9	7/25/15 19:50 == 44.7	7/26/15 0:25 == 44.8
7/25/15 10:45 == 45.4	7/25/15 15:20 == 44.9	7/25/15 19:55 == 44.8	7/26/15 0:30 == 44.9
7/25/15 10:50 == 45.5	7/25/15 15:25 == 44.8	7/25/15 20:00 == 44.9	7/26/15 0:35 == 44.9
7/25/15 10:55 == 45.6	7/25/15 15:30 == 44.8	7/25/15 20:05 == 44.8	7/26/15 0:40 == 44.8
7/25/15 11:00 == 45.2	7/25/15 15:35 == 44.7	7/25/15 20:10 == 44.8	7/26/15 0:45 == 44.8
7/25/15 11:05 == 45.3	7/25/15 15:40 == 44.8	7/25/15 20:15 == 44.7	7/26/15 0:50 == 44.9
7/25/15 11:10 == 45.4	7/25/15 15:45 == 44.8	7/25/15 20:20 == 44.8	7/26/15 0:55 == 44.9
7/25/15 11:15 == 45.3	7/25/15 15:50 == 44.8	7/25/15 20:25 == 44.8	7/26/15 1:00 == 44.9
7/25/15 11:20 == 45.3	7/25/15 15:55 == 44.8	7/25/15 20:30 == 44.7	7/26/15 1:05 == 44.9
7/25/15 11:25 == 45.1	7/25/15 16:00 == 44.9	7/25/15 20:35 == 44.7	7/26/15 1:10 == 45
7/25/15 11:30 == 45.2	7/25/15 16:05 == 44.8	7/25/15 20:40 == 44.8	7/26/15 1:15 == 44.8
7/25/15 11:35 == 45.4	7/25/15 16:10 == 44.8	7/25/15 20:45 == 44.8	7/26/15 1:20 == 44.8
7/25/15 11:40 == 45.2	7/25/15 16:15 == 44.8	7/25/15 20:50 == 44.8	7/26/15 1:25 == 44.9
7/25/15 11:45 == 45.2	7/25/15 16:20 == 44.7	7/25/15 20:55 == 44.7	7/26/15 1:30 == 44.9
7/25/15 11:50 == 45.2	7/25/15 16:25 == 45	7/25/15 21:00 == 44.8	7/26/15 1:35 == 44.9
7/25/15 11:55 == 45.5	7/25/15 16:30 == 44.8	7/25/15 21:05 == 44.8	7/26/15 1:40 == 44.9
7/25/15 12:00 == 45.6	7/25/15 16:35 == 44.8	7/25/15 21:10 == 44.9	7/26/15 1:45 == 44.9
7/25/15 12:05 == 45.2	7/25/15 16:40 == 44.8	7/25/15 21:15 == 44.8	7/26/15 1:50 == 44.9
7/25/15 12:10 == 45.2	7/25/15 16:45 == 44.8	7/25/15 21:20 == 44.8	7/26/15 1:55 == 45
7/25/15 12:15 == 45.1	7/25/15 16:50 == 44.7	7/25/15 21:25 == 44.9	7/26/15 2:00 == 44.9
7/25/15 12:20 == 45.5	7/25/15 16:55 == 44.8	7/25/15 21:30 == 44.7	7/26/15 2:05 == 44.9
7/25/15 12:25 == 45	7/25/15 17:00 == 44.8	7/25/15 21:35 == 44.8	7/26/15 2:10 == 44.9
7/25/15 12:30 == 45.5	7/25/15 17:05 == 44.8	7/25/15 21:40 == 44.8	7/26/15 2:15 == 44.8
7/25/15 12:35 == 45.1	7/25/15 17:10 == 44.8	7/25/15 21:45 == 44.7	7/26/15 2:20 == 44.8
7/25/15 12:40 == 45.2	7/25/15 17:15 == 44.8	7/25/15 21:50 == 44.9	7/26/15 2:25 == 44.9
7/25/15 12:45 == 45.2	7/25/15 17:20 == 44.8	7/25/15 21:55 == 44.8	7/26/15 2:30 == 44.9
7/25/15 12:50 == 45.2	7/25/15 17:25 == 44.9	7/25/15 22:00 == 44.8	7/26/15 2:35 == 44.9
7/25/15 12:55 == 45.5	7/25/15 17:30 == 44.8	7/25/15 22:05 == 44.9	7/26/15 2:40 == 45
7/25/15 13:00 == 45.4	7/25/15 17:35 == 44.9	7/25/15 22:10 == 44.8	7/26/15 2:45 == 44.8
7/25/15 13:05 == 45.2	7/25/15 17:40 == 44.9	7/25/15 22:15 == 44.8	7/26/15 2:50 == 44.9
7/25/15 13:10 == 45.1	7/25/15 17:45 == 44.7	7/25/15 22:20 == 44.7	7/26/15 2:55 == 44.9
7/25/15 13:15 == 45.4	7/25/15 17:50 == 44.8	7/25/15 22:25 == 44.8	7/26/15 3:00 == 44.9
7/25/15 13:20 == 45.1	7/25/15 17:55 == 44.9	7/25/15 22:30 == 44.7	7/26/15 3:05 == 44.8
7/25/15 13:25 == 45.1	7/25/15 18:00 == 44.8	7/25/15 22:35 == 44.8	7/26/15 3:10 == 44.9
7/25/15 13:30 == 45.2	7/25/15 18:05 == 44.8	7/25/15 22:40 == 44.8	7/26/15 3:15 == 44.9
7/25/15 13:35 == 45.3	7/25/15 18:10 == 44.8	7/25/15 22:45 == 44.7	7/26/15 3:20 == 44.9
7/25/15 13:40 == 45.2	7/25/15 18:15 == 44.8	7/25/15 22:50 == 44.9	7/26/15 3:25 == 44.8
7/25/15 13:45 == 45.2	7/25/15 18:20 == 44.8	7/25/15 22:55 == 44.9	7/26/15 3:30 == 44.9
7/25/15 13:50 == 45.1	7/25/15 18:25 == 44.7	7/25/15 23:00 == 44.7	7/26/15 3:35 == 44.9
7/25/15 13:55 == 45.1	7/25/15 18:30 == 44.9	7/25/15 23:05 == 44.8	7/26/15 3:40 == 44.9
7/25/15 14:00 == 45.1	7/25/15 18:35 == 44.8	7/25/15 23:10 == 44.8	7/26/15 3:45 == 44.9
7/25/15 14:05 == 45.2	7/25/15 18:40 == 44.9	7/25/15 23:15 == 44.8	7/26/15 3:50 == 44.9
7/25/15 14:10 == 45.1	7/25/15 18:45 == 44.9	7/25/15 23:20 == 44.8	7/26/15 3:55 == 44.8
7/25/15 14:15 == 45	7/25/15 18:50 == 44.9	7/25/15 23:25 == 44.9	7/26/15 4:00 == 44.9
7/25/15 14:20 == 44.9	7/25/15 18:55 == 44.9	7/25/15 23:30 == 44.8	7/26/15 4:05 == 44.9
7/25/15 14:25 == 44.9	7/25/15 19:00 == 44.8	7/25/15 23:35 == 44.9	7/26/15 4:10 == 44.9
7/25/15 14:30 == 44.8	7/25/15 19:05 == 44.8	7/25/15 23:40 == 44.8	7/26/15 4:15 == 44.9
7/25/15 14:35 == 44.8	7/25/15 19:10 == 44.9	7/25/15 23:45 == 45	7/26/15 4:20 == 44.9
7/25/15 14:40 == 45	7/25/15 19:15 == 44.7	7/25/15 23:50 == 44.9	7/26/15 4:25 == 44.8
7/25/15 14:45 == 44.8	7/25/15 19:20 == 44.7	7/25/15 23:55 == 44.8	7/26/15 4:30 == 45
7/25/15 14:50 == 44.8	7/25/15 19:25 == 44.7	7/26/15 0:00 == 44.8	7/26/15 4:35 == 44.8
7/25/15 14:55 == 44.9	7/25/15 19:30 == 44.8	7/26/15 0:05 == 44.8	7/26/15 4:40 == 44.8
7/25/15 15:00 == 44.9	7/25/15 19:35 == 44.8	7/26/15 0:10 == 44.8	7/26/15 4:45 == 44.9
7/25/15 15:05 == 44.9	7/25/15 19:40 == 44.8	7/26/15 0:15 == 44.8	7/26/15 4:50 == 45
7/25/15 15:10 == 44.7	7/25/15 19:45 == 44.9	7/26/15 0:20 == 44.9	7/26/15 4:55 == 44.9

Pumpback Station Discharge (0364)

7/26/15 5:00 == 44.9	7/26/15 9:35 == 45.1	7/26/15 14:10 == 44.8	7/26/15 18:45 == 44.8
7/26/15 5:05 == 44.8	7/26/15 9:40 == 45	7/26/15 14:15 == 44.7	7/26/15 18:50 == 44.8
7/26/15 5:10 == 44.9	7/26/15 9:45 == 45	7/26/15 14:20 == 44.8	7/26/15 18:55 == 44.8
7/26/15 5:15 == 44.9	7/26/15 9:50 == 45	7/26/15 14:25 == 44.8	7/26/15 19:00 == 44.8
7/26/15 5:20 == 44.9	7/26/15 9:55 == 45	7/26/15 14:30 == 44.8	7/26/15 19:05 == 44.7
7/26/15 5:25 == 44.9	7/26/15 10:00 == 44.9	7/26/15 14:35 == 44.8	7/26/15 19:10 == 44.7
7/26/15 5:30 == 44.9	7/26/15 10:05 == 45.1	7/26/15 14:40 == 44.8	7/26/15 19:15 == 44.8
7/26/15 5:35 == 44.8	7/26/15 10:10 == 44.9	7/26/15 14:45 == 44.8	7/26/15 19:20 == 44.8
7/26/15 5:40 == 44.9	7/26/15 10:15 == 44.9	7/26/15 14:50 == 44.7	7/26/15 19:25 == 44.8
7/26/15 5:45 == 45	7/26/15 10:20 == 44.9	7/26/15 14:55 == 44.9	7/26/15 19:30 == 44.9
7/26/15 5:50 == 44.9	7/26/15 10:25 == 45	7/26/15 15:00 == 44.8	7/26/15 19:35 == 44.7
7/26/15 5:55 == 44.9	7/26/15 10:30 == 44.9	7/26/15 15:05 == 44.7	7/26/15 19:40 == 44.7
7/26/15 6:00 == 44.9	7/26/15 10:35 == 44.7	7/26/15 15:10 == 44.7	7/26/15 19:45 == 44.8
7/26/15 6:05 == 44.9	7/26/15 10:40 == 44.8	7/26/15 15:15 == 44.8	7/26/15 19:50 == 44.8
7/26/15 6:10 == 44.8	7/26/15 10:45 == 45	7/26/15 15:20 == 44.8	7/26/15 19:55 == 44.8
7/26/15 6:15 == 44.9	7/26/15 10:50 == 44.9	7/26/15 15:25 == 44.7	7/26/15 20:00 == 44.7
7/26/15 6:20 == 44.8	7/26/15 10:55 == 45	7/26/15 15:30 == 44.7	7/26/15 20:05 == 44.8
7/26/15 6:25 == 44.8	7/26/15 11:00 == 45	7/26/15 15:35 == 44.7	7/26/15 20:10 == 44.7
7/26/15 6:30 == 44.9	7/26/15 11:05 == 44.9	7/26/15 15:40 == 44.9	7/26/15 20:15 == 44.7
7/26/15 6:35 == 44.9	7/26/15 11:10 == 45	7/26/15 15:45 == 44.8	7/26/15 20:20 == 44.8
7/26/15 6:40 == 44.9	7/26/15 11:15 == 45	7/26/15 15:50 == 44.8	7/26/15 20:25 == 44.7
7/26/15 6:45 == 44.9	7/26/15 11:20 == 44.9	7/26/15 15:55 == 44.7	7/26/15 20:30 == 44.8
7/26/15 6:50 == 44.9	7/26/15 11:25 == 44.8	7/26/15 16:00 == 44.7	7/26/15 20:35 == 44.8
7/26/15 6:55 == 44.8	7/26/15 11:30 == 44.8	7/26/15 16:05 == 44.8	7/26/15 20:40 == 44.7
7/26/15 7:00 == 44.9	7/26/15 11:35 == 44.8	7/26/15 16:10 == 44.8	7/26/15 20:45 == 44.8
7/26/15 7:05 == 44.9	7/26/15 11:40 == 44.9	7/26/15 16:15 == 44.7	7/26/15 20:50 == 44.8
7/26/15 7:10 == 44.8	7/26/15 11:45 == 44.9	7/26/15 16:20 == 44.7	7/26/15 20:55 == 44.9
7/26/15 7:15 == 44.9	7/26/15 11:50 == 44.8	7/26/15 16:25 == 44.8	7/26/15 21:00 == 44.8
7/26/15 7:20 == 44.9	7/26/15 11:55 == 44.9	7/26/15 16:30 == 44.8	7/26/15 21:05 == 44.8
7/26/15 7:25 == 44.9	7/26/15 12:00 == 44.9	7/26/15 16:35 == 44.8	7/26/15 21:10 == 44.9
7/26/15 7:30 == 44.9	7/26/15 12:05 == 44.9	7/26/15 16:40 == 44.8	7/26/15 21:15 == 44.8
7/26/15 7:35 == 44.8	7/26/15 12:10 == 44.7	7/26/15 16:45 == 44.8	7/26/15 21:20 == 44.7
7/26/15 7:40 == 44.9	7/26/15 12:15 == 44.9	7/26/15 16:50 == 44.8	7/26/15 21:25 == 44.8
7/26/15 7:45 == 44.8	7/26/15 12:20 == 44.8	7/26/15 16:55 == 44.7	7/26/15 21:30 == 44.8
7/26/15 7:50 == 44.8	7/26/15 12:25 == 44.8	7/26/15 17:00 == 44.8	7/26/15 21:35 == 44.9
7/26/15 7:55 == 44.9	7/26/15 12:30 == 44.8	7/26/15 17:05 == 44.8	7/26/15 21:40 == 44.8
7/26/15 8:00 == 45	7/26/15 12:35 == 44.9	7/26/15 17:10 == 44.8	7/26/15 21:45 == 44.8
7/26/15 8:05 == 44.8	7/26/15 12:40 == 44.8	7/26/15 17:15 == 44.8	7/26/15 21:50 == 44.8
7/26/15 8:10 == 44.9	7/26/15 12:45 == 44.8	7/26/15 17:20 == 44.7	7/26/15 21:55 == 44.8
7/26/15 8:15 == 45	7/26/15 12:50 == 44.7	7/26/15 17:25 == 44.7	7/26/15 22:00 == 44.7
7/26/15 8:20 == 44.8	7/26/15 12:55 == 44.8	7/26/15 17:30 == 44.8	7/26/15 22:05 == 44.8
7/26/15 8:25 == 44.8	7/26/15 13:00 == 44.8	7/26/15 17:35 == 44.8	7/26/15 22:10 == 44.9
7/26/15 8:30 == 44.9	7/26/15 13:05 == 44.8	7/26/15 17:40 == 44.7	7/26/15 22:15 == 44.8
7/26/15 8:35 == 45.1	7/26/15 13:10 == 44.8	7/26/15 17:45 == 44.7	7/26/15 22:20 == 44.7
7/26/15 8:40 == 45	7/26/15 13:15 == 44.9	7/26/15 17:50 == 44.7	7/26/15 22:25 == 44.9
7/26/15 8:45 == 45	7/26/15 13:20 == 44.8	7/26/15 17:55 == 44.8	7/26/15 22:30 == 44.8
7/26/15 8:50 == 45	7/26/15 13:25 == 44.9	7/26/15 18:00 == 44.7	7/26/15 22:35 == 44.8
7/26/15 8:55 == 44.9	7/26/15 13:30 == 44.8	7/26/15 18:05 == 44.8	7/26/15 22:40 == 44.8
7/26/15 9:00 == 45	7/26/15 13:35 == 44.9	7/26/15 18:10 == 44.7	7/26/15 22:45 == 44.8
7/26/15 9:05 == 44.9	7/26/15 13:40 == 44.8	7/26/15 18:15 == 44.7	7/26/15 22:50 == 44.9
7/26/15 9:10 == 44.9	7/26/15 13:45 == 44.8	7/26/15 18:20 == 44.8	7/26/15 22:55 == 44.8
7/26/15 9:15 == 44.9	7/26/15 13:50 == 44.8	7/26/15 18:25 == 44.7	7/26/15 23:00 == 44.9
7/26/15 9:20 == 44.9	7/26/15 13:55 == 44.8	7/26/15 18:30 == 44.8	7/26/15 23:05 == 45
7/26/15 9:25 == 44.9	7/26/15 14:00 == 44.9	7/26/15 18:35 == 44.7	7/26/15 23:10 == 44.8
7/26/15 9:30 == 45.1	7/26/15 14:05 == 44.8	7/26/15 18:40 == 44.8	7/26/15 23:15 == 44.8

Pumpback Station Discharge (0364)

7/26/15 23:20 == 44.8	7/27/15 3:55 == 44.7	7/27/15 8:30 == 46.5	7/27/15 13:05 == 46.7
7/26/15 23:25 == 44.8	7/27/15 4:00 == 44.8	7/27/15 8:35 == 46.7	7/27/15 13:10 == 47.1
7/26/15 23:30 == 44.8	7/27/15 4:05 == 44.8	7/27/15 8:40 == 46.8	7/27/15 13:15 == 46.5
7/26/15 23:35 == 44.8	7/27/15 4:10 == 44.8	7/27/15 8:45 == 46.7	7/27/15 13:20 == 46.8
7/26/15 23:40 == 44.9	7/27/15 4:15 == 44.7	7/27/15 8:50 == 46.7	7/27/15 13:25 == 47
7/26/15 23:45 == 44.8	7/27/15 4:20 == 44.7	7/27/15 8:55 == 46.6	7/27/15 13:30 == 46.5
7/26/15 23:50 == 44.9	7/27/15 4:25 == 44.8	7/27/15 9:00 == 46.9	7/27/15 13:35 == 46.6
7/26/15 23:55 == 44.8	7/27/15 4:30 == 44.8	7/27/15 9:05 == 46.5	7/27/15 13:40 == 46.6
7/27/15 0:00 == 44.8	7/27/15 4:35 == 44.8	7/27/15 9:10 == 46.9	7/27/15 13:45 == 47
7/27/15 0:05 == 44.8	7/27/15 4:40 == 45.1	7/27/15 9:15 == 47.2	7/27/15 13:50 == 46.7
7/27/15 0:10 == 44.8	7/27/15 4:45 == 44.8	7/27/15 9:20 == 46.9	7/27/15 13:55 == 46.5
7/27/15 0:15 == 44.8	7/27/15 4:50 == 44.8	7/27/15 9:25 == 46.5	7/27/15 14:00 == 46.7
7/27/15 0:20 == 44.8	7/27/15 4:55 == 44.6	7/27/15 9:30 == 46.7	7/27/15 14:05 == 46.8
7/27/15 0:25 == 44.7	7/27/15 5:00 == 44.9	7/27/15 9:35 == 46.7	7/27/15 14:10 == 46.8
7/27/15 0:30 == 44.9	7/27/15 5:05 == 45	7/27/15 9:40 == 46.7	7/27/15 14:15 == 47
7/27/15 0:35 == 44.8	7/27/15 5:10 == 44.8	7/27/15 9:45 == 46.6	7/27/15 14:20 == 46.6
7/27/15 0:40 == 44.8	7/27/15 5:15 == 45	7/27/15 9:50 == 46.9	7/27/15 14:25 == 46.7
7/27/15 0:45 == 44.7	7/27/15 5:20 == 44.8	7/27/15 9:55 == 46.8	7/27/15 14:30 == 46.9
7/27/15 0:50 == 44.7	7/27/15 5:25 == 45	7/27/15 10:00 == 46.8	7/27/15 14:35 == 46.8
7/27/15 0:55 == 44.8	7/27/15 5:30 == 44.8	7/27/15 10:05 == 46.5	7/27/15 14:40 == 46.6
7/27/15 1:00 == 44.8	7/27/15 5:35 == 44.7	7/27/15 10:10 == 46.4	7/27/15 14:45 == 46.7
7/27/15 1:05 == 44.8	7/27/15 5:40 == 44.8	7/27/15 10:15 == 46.3	7/27/15 14:50 == 46.6
7/27/15 1:10 == 44.7	7/27/15 5:45 == 45	7/27/15 10:20 == 46.7	7/27/15 14:55 == 46.5
7/27/15 1:15 == 44.8	7/27/15 5:50 == 45	7/27/15 10:25 == 46.4	7/27/15 15:00 == 46.6
7/27/15 1:20 == 44.8	7/27/15 5:55 == 45.1	7/27/15 10:30 == 46.6	7/27/15 15:05 == 46.4
7/27/15 1:25 == 44.7	7/27/15 6:00 == 44.9	7/27/15 10:35 == 46.6	7/27/15 15:10 == 47.2
7/27/15 1:30 == 44.8	7/27/15 6:05 == 44.9	7/27/15 10:40 == 46.6	7/27/15 15:15 == 46.5
7/27/15 1:35 == 44.8	7/27/15 6:10 == 44.8	7/27/15 10:45 == 46.8	7/27/15 15:20 == 46.6
7/27/15 1:40 == 44.8	7/27/15 6:15 == 45.3	7/27/15 10:50 == 46.6	7/27/15 15:25 == 46.7
7/27/15 1:45 == 44.8	7/27/15 6:20 == 45.5	7/27/15 10:55 == 46.6	7/27/15 15:30 == 47.2
7/27/15 1:50 == 44.8	7/27/15 6:25 == 45.3	7/27/15 11:00 == 46.5	7/27/15 15:35 == 46.7
7/27/15 1:55 == 44.8	7/27/15 6:30 == 46	7/27/15 11:05 == 46.8	7/27/15 15:40 == 46.4
7/27/15 2:00 == 44.7	7/27/15 6:35 == 44.9	7/27/15 11:10 == 46.8	7/27/15 15:45 == 46.9
7/27/15 2:05 == 44.8	7/27/15 6:40 == 45.5	7/27/15 11:15 == 46.5	7/27/15 15:50 == 46.6
7/27/15 2:10 == 44.8	7/27/15 6:45 == 45.5	7/27/15 11:20 == 46.7	7/27/15 15:55 == 46.6
7/27/15 2:15 == 44.7	7/27/15 6:50 == 46.3	7/27/15 11:25 == 46.4	7/27/15 16:00 == 46.7
7/27/15 2:20 == 44.8	7/27/15 6:55 == 46.1	7/27/15 11:30 == 46.6	7/27/15 16:05 == 46.6
7/27/15 2:25 == 44.8	7/27/15 7:00 == 46	7/27/15 11:35 == 46.5	7/27/15 16:10 == 46.8
7/27/15 2:30 == 44.8	7/27/15 7:05 == 46.1	7/27/15 11:40 == 46.5	7/27/15 16:15 == 46.1
7/27/15 2:35 == 44.9	7/27/15 7:10 == 46.8	7/27/15 11:45 == 46.7	7/27/15 16:20 == 46.2
7/27/15 2:40 == 44.7	7/27/15 7:15 == 46.7	7/27/15 11:50 == 46.7	7/27/15 16:25 == 46
7/27/15 2:45 == 44.8	7/27/15 7:20 == 46.8	7/27/15 11:55 == 46.9	7/27/15 16:30 == 46.1
7/27/15 2:50 == 44.8	7/27/15 7:25 == 46.7	7/27/15 12:00 == 46.6	7/27/15 16:35 == 45.9
7/27/15 2:55 == 44.9	7/27/15 7:30 == 46.8	7/27/15 12:05 == 46.6	7/27/15 16:40 == 46
7/27/15 3:00 == 44.8	7/27/15 7:35 == 46.7	7/27/15 12:10 == 46.6	7/27/15 16:45 == 46
7/27/15 3:05 == 44.7	7/27/15 7:40 == 46.7	7/27/15 12:15 == 46.6	7/27/15 16:50 == 45.9
7/27/15 3:10 == 44.9	7/27/15 7:45 == 46.4	7/27/15 12:20 == 46.7	7/27/15 16:55 == 46
7/27/15 3:15 == 44.7	7/27/15 7:50 == 46.8	7/27/15 12:25 == 46.8	7/27/15 17:00 == 46
7/27/15 3:20 == 44.8	7/27/15 7:55 == 46.6	7/27/15 12:30 == 46.7	7/27/15 17:05 == 45.9
7/27/15 3:25 == 44.8	7/27/15 8:00 == 46.5	7/27/15 12:35 == 46.6	7/27/15 17:10 == 46
7/27/15 3:30 == 44.8	7/27/15 8:05 == 46.6	7/27/15 12:40 == 46.6	7/27/15 17:15 == 46
7/27/15 3:35 == 44.8	7/27/15 8:10 == 46.7	7/27/15 12:45 == 46.8	7/27/15 17:20 == 46
7/27/15 3:40 == 44.8	7/27/15 8:15 == 46.6	7/27/15 12:50 == 46.6	7/27/15 17:25 == 45.9
7/27/15 3:45 == 44.8	7/27/15 8:20 == 46.5	7/27/15 12:55 == 47	7/27/15 17:30 == 46
7/27/15 3:50 == 44.8	7/27/15 8:25 == 46.8	7/27/15 13:00 == 46.6	7/27/15 17:35 == 46

Pumpback Station Discharge (0364)

7/27/15 17:40 == 45.9	7/27/15 22:15 == 45.9	7/28/15 2:50 == 45.9	7/28/15 7:25 == 32.1
7/27/15 17:45 == 45.9	7/27/15 22:20 == 45.9	7/28/15 2:55 == 46.1	7/28/15 7:30 == 32.2
7/27/15 17:50 == 46	7/27/15 22:25 == 46	7/28/15 3:00 == 46	7/28/15 7:35 == 32.2
7/27/15 17:55 == 45.9	7/27/15 22:30 == 46	7/28/15 3:05 == 46.2	7/28/15 7:40 == 32.2
7/27/15 18:00 == 32.3	7/27/15 22:35 == 46	7/28/15 3:10 == 46	7/28/15 7:45 == 32.4
7/27/15 18:05 == 31.7	7/27/15 22:40 == 46	7/28/15 3:15 == 45.9	7/28/15 7:50 == 32.5
7/27/15 18:10 == 31.6	7/27/15 22:45 == 46	7/28/15 3:20 == 45.9	7/28/15 7:55 == 31.9
7/27/15 18:15 == 32.2	7/27/15 22:50 == 45.9	7/28/15 3:25 == 45.9	7/28/15 8:00 == 32.4
7/27/15 18:20 == 32.1	7/27/15 22:55 == 46	7/28/15 3:30 == 45.9	7/28/15 8:05 == 32.6
7/27/15 18:25 == 32.1	7/27/15 23:00 == 32.2	7/28/15 3:35 == 46	7/28/15 8:10 == 32.2
7/27/15 18:30 == 32.5	7/27/15 23:05 == 31.8	7/28/15 3:40 == 46.1	7/28/15 8:15 == 32.6
7/27/15 18:35 == 32.5	7/27/15 23:10 == 31.7	7/28/15 3:45 == 32.1	7/28/15 8:20 == 32.5
7/27/15 18:40 == 32.5	7/27/15 23:15 == 32.4	7/28/15 3:50 == 31.8	7/28/15 8:25 == 32.6
7/27/15 18:45 == 40.1	7/27/15 23:20 == 32.3	7/28/15 3:55 == 31.7	7/28/15 8:30 == 32.7
7/27/15 18:50 == 46	7/27/15 23:25 == 32.3	7/28/15 4:00 == 32.1	7/28/15 8:35 == 32.5
7/27/15 18:55 == 45.9	7/27/15 23:30 == 32.4	7/28/15 4:05 == 32.2	7/28/15 8:40 == 32.5
7/27/15 19:00 == 46	7/27/15 23:35 == 32.5	7/28/15 4:10 == 32.2	7/28/15 8:45 == 32.7
7/27/15 19:05 == 45.8	7/27/15 23:40 == 32.4	7/28/15 4:15 == 32.3	7/28/15 8:50 == 32.7
7/27/15 19:10 == 46.2	7/27/15 23:45 == 32.8	7/28/15 4:20 == 32.3	7/28/15 8:55 == 32.7
7/27/15 19:15 == 46	7/27/15 23:50 == 32.8	7/28/15 4:25 == 32.4	7/28/15 9:00 == 32.8
7/27/15 19:20 == 45.9	7/27/15 23:55 == 32.9	7/28/15 4:30 == 32.7	7/28/15 9:05 == 33
7/27/15 19:25 == 46	7/28/15 0:00 == 40.4	7/28/15 4:35 == 32.7	7/28/15 9:10 == 32.6
7/27/15 19:30 == 45.9	7/28/15 0:05 == 46	7/28/15 4:40 == 32.6	7/28/15 9:15 == 32.8
7/27/15 19:35 == 46	7/28/15 0:10 == 46.1	7/28/15 4:45 == 32.7	7/28/15 9:20 == 32.7
7/27/15 19:40 == 45.9	7/28/15 0:15 == 46	7/28/15 4:50 == 32.7	7/28/15 9:25 == 32.9
7/27/15 19:45 == 46	7/28/15 0:20 == 46	7/28/15 4:55 == 32.7	7/28/15 9:30 == 33
7/27/15 19:50 == 45.9	7/28/15 0:25 == 46	7/28/15 5:00 == 32.9	7/28/15 9:35 == 32.8
7/27/15 19:55 == 45.9	7/28/15 0:30 == 46	7/28/15 5:05 == 33	7/28/15 9:40 == 33
7/27/15 20:00 == 46	7/28/15 0:35 == 45.9	7/28/15 5:10 == 32.7	7/28/15 9:45 == 33.1
7/27/15 20:05 == 45.9	7/28/15 0:40 == 46	7/28/15 5:15 == 40.7	7/28/15 9:50 == 32.9
7/27/15 20:10 == 45.9	7/28/15 0:45 == 45.9	7/28/15 5:20 == 46.2	7/28/15 9:55 == 33.1
7/27/15 20:15 == 45.9	7/28/15 0:50 == 46	7/28/15 5:25 == 46.2	7/28/15 10:00 == 41.1
7/27/15 20:20 == 45.9	7/28/15 0:55 == 46	7/28/15 5:30 == 45.9	7/28/15 10:05 == 47
7/27/15 20:25 == 46	7/28/15 1:00 == 46.1	7/28/15 5:35 == 45.9	7/28/15 10:10 == 46.4
7/27/15 20:30 == 45.9	7/28/15 1:05 == 46.3	7/28/15 5:40 == 45.9	7/28/15 10:15 == 46.8
7/27/15 20:35 == 45.9	7/28/15 1:10 == 46.1	7/28/15 5:45 == 46.1	7/28/15 10:20 == 46.9
7/27/15 20:40 == 46	7/28/15 1:15 == 31.8	7/28/15 5:50 == 46.2	7/28/15 10:25 == 46.8
7/27/15 20:45 == 32.2	7/28/15 1:20 == 31.4	7/28/15 5:55 == 45.8	7/28/15 10:30 == 46.9
7/27/15 20:50 == 31.7	7/28/15 1:25 == 31.5	7/28/15 6:00 == 46	7/28/15 10:35 == 46.7
7/27/15 20:55 == 31.6	7/28/15 1:30 == 32	7/28/15 6:05 == 46.3	7/28/15 10:40 == 46.8
7/27/15 21:00 == 32	7/28/15 1:35 == 31.9	7/28/15 6:10 == 45.8	7/28/15 10:45 == 46.8
7/27/15 21:05 == 31.9	7/28/15 1:40 == 32	7/28/15 6:15 == 32.3	7/28/15 10:50 == 46.7
7/27/15 21:10 == 32.2	7/28/15 1:45 == 32.2	7/28/15 6:20 == 31.8	7/28/15 10:55 == 46.8
7/27/15 21:15 == 32.6	7/28/15 1:50 == 32.2	7/28/15 6:25 == 31.9	7/28/15 11:00 == 46.7
7/27/15 21:20 == 32.6	7/28/15 1:55 == 32.2	7/28/15 6:30 == 32.2	7/28/15 11:05 == 46.6
7/27/15 21:25 == 32.5	7/28/15 2:00 == 32.4	7/28/15 6:35 == 32.2	7/28/15 11:10 == 47.2
7/27/15 21:30 == 32.8	7/28/15 2:05 == 32.5	7/28/15 6:40 == 32.3	7/28/15 11:15 == 46.6
7/27/15 21:35 == 32.8	7/28/15 2:10 == 32.4	7/28/15 6:45 == 32.3	7/28/15 11:20 == 46.6
7/27/15 21:40 == 32.8	7/28/15 2:15 == 32.7	7/28/15 6:50 == 32.6	7/28/15 11:25 == 46.4
7/27/15 21:45 == 40.3	7/28/15 2:20 == 32.7	7/28/15 6:55 == 32.5	7/28/15 11:30 == 32.2
7/27/15 21:50 == 46	7/28/15 2:25 == 32.7	7/28/15 7:00 == 32.4	7/28/15 11:35 == 31.9
7/27/15 21:55 == 46	7/28/15 2:30 == 32.8	7/28/15 7:05 == 32.3	7/28/15 11:40 == 31.5
7/27/15 22:00 == 46	7/28/15 2:35 == 32.9	7/28/15 7:10 == 32.1	7/28/15 11:45 == 32.4
7/27/15 22:05 == 46.1	7/28/15 2:40 == 32.9	7/28/15 7:15 == 31.9	7/28/15 11:50 == 32.3
7/27/15 22:10 == 46	7/28/15 2:45 == 40.4	7/28/15 7:20 == 32.2	7/28/15 11:55 == 32.5

Pumpback Station Discharge (0364)

7/28/15 12:00 == 32.3	7/28/15 16:35 == 45.7	7/28/15 21:10 == 32.3	7/29/15 1:45 == 31.8
7/28/15 12:05 == 32.6	7/28/15 16:40 == 44.8	7/28/15 21:15 == 42	7/29/15 1:50 == 31.6
7/28/15 12:10 == 32.3	7/28/15 16:45 == 31.8	7/28/15 21:20 == 45.7	7/29/15 1:55 == 31.7
7/28/15 12:15 == 32.6	7/28/15 16:50 == 31.6	7/28/15 21:25 == 45.7	7/29/15 2:00 == 32
7/28/15 12:20 == 32.7	7/28/15 16:55 == 31.6	7/28/15 21:30 == 45.8	7/29/15 2:05 == 32
7/28/15 12:25 == 32.6	7/28/15 17:00 == 32	7/28/15 21:35 == 45.7	7/29/15 2:10 == 32.1
7/28/15 12:30 == 32.8	7/28/15 17:05 == 32	7/28/15 21:40 == 45.7	7/29/15 2:15 == 32
7/28/15 12:35 == 32.9	7/28/15 17:10 == 32.4	7/28/15 21:45 == 45.7	7/29/15 2:20 == 32
7/28/15 12:40 == 32.6	7/28/15 17:15 == 32.4	7/28/15 21:50 == 45.7	7/29/15 2:25 == 32.1
7/28/15 12:45 == 42.2	7/28/15 17:20 == 32.2	7/28/15 21:55 == 45.8	7/29/15 2:30 == 32.2
7/28/15 12:50 == 47.1	7/28/15 17:25 == 32.3	7/28/15 22:00 == 45.6	7/29/15 2:35 == 32.2
7/28/15 12:55 == 47	7/28/15 17:30 == 32.5	7/28/15 22:05 == 45.6	7/29/15 2:40 == 32.2
7/28/15 13:00 == 46.7	7/28/15 17:35 == 32.3	7/28/15 22:10 == 44.3	7/29/15 2:45 == 32.4
7/28/15 13:05 == 46.8	7/28/15 17:40 == 32.5	7/28/15 22:15 == 31.7	7/29/15 2:50 == 32.3
7/28/15 13:10 == 47.1	7/28/15 17:45 == 32.5	7/28/15 22:20 == 31.4	7/29/15 2:55 == 32.4
7/28/15 13:15 == 46.8	7/28/15 17:50 == 32.4	7/28/15 22:25 == 31.6	7/29/15 3:00 == 32.3
7/28/15 13:20 == 46.9	7/28/15 17:55 == 32.5	7/28/15 22:30 == 31.8	7/29/15 3:05 == 32.4
7/28/15 13:25 == 46.8	7/28/15 18:00 == 32.7	7/28/15 22:35 == 31.8	7/29/15 3:10 == 32.4
7/28/15 13:30 == 47	7/28/15 18:05 == 32.6	7/28/15 22:40 == 31.9	7/29/15 3:15 == 32.8
7/28/15 13:35 == 46.9	7/28/15 18:10 == 32.6	7/28/15 22:45 == 32.1	7/29/15 3:20 == 32.7
7/28/15 13:40 == 46.8	7/28/15 18:15 == 32.7	7/28/15 22:50 == 32	7/29/15 3:25 == 32.7
7/28/15 13:45 == 46.9	7/28/15 18:20 == 32.8	7/28/15 22:55 == 32.1	7/29/15 3:30 == 32.8
7/28/15 13:50 == 46.7	7/28/15 18:25 == 32.7	7/28/15 23:00 == 32	7/29/15 3:35 == 32.7
7/28/15 13:55 == 46	7/28/15 18:30 == 32.8	7/28/15 23:05 == 32.1	7/29/15 3:40 == 32.8
7/28/15 14:00 == 32.1	7/28/15 18:35 == 32.7	7/28/15 23:10 == 32.2	7/29/15 3:45 == 32.6
7/28/15 14:05 == 32	7/28/15 18:40 == 32.3	7/28/15 23:15 == 32.2	7/29/15 3:50 == 32.7
7/28/15 14:10 == 31.7	7/28/15 18:45 == 42	7/28/15 23:20 == 32.4	7/29/15 3:55 == 32.6
7/28/15 14:15 == 32.5	7/28/15 18:50 == 45.6	7/28/15 23:25 == 32.4	7/29/15 4:00 == 32.7
7/28/15 14:20 == 32.3	7/28/15 18:55 == 45.7	7/28/15 23:30 == 32.4	7/29/15 4:05 == 32.6
7/28/15 14:25 == 32.4	7/28/15 19:00 == 45.6	7/28/15 23:35 == 32.2	7/29/15 4:10 == 32.7
7/28/15 14:30 == 32.8	7/28/15 19:05 == 45.7	7/28/15 23:40 == 32.3	7/29/15 4:15 == 32.7
7/28/15 14:35 == 32.8	7/28/15 19:10 == 45.8	7/28/15 23:45 == 32.6	7/29/15 4:20 == 32.6
7/28/15 14:40 == 32.8	7/28/15 19:15 == 45.7	7/28/15 23:50 == 32.6	7/29/15 4:25 == 32.7
7/28/15 14:45 == 32.6	7/28/15 19:20 == 45.8	7/28/15 23:55 == 32.4	7/29/15 4:30 == 32.8
7/28/15 14:50 == 32.7	7/28/15 19:25 == 45.7	7/29/15 0:00 == 32.6	7/29/15 4:35 == 32.7
7/28/15 14:55 == 32.9	7/28/15 19:30 == 45.7	7/29/15 0:05 == 32.7	7/29/15 4:40 == 32.8
7/28/15 15:00 == 33.1	7/28/15 19:35 == 45.6	7/29/15 0:10 == 32.5	7/29/15 4:45 == 32.9
7/28/15 15:05 == 33	7/28/15 19:40 == 44.5	7/29/15 0:15 == 32.7	7/29/15 4:50 == 32.8
7/28/15 15:10 == 32.8	7/28/15 19:45 == 32	7/29/15 0:20 == 32.6	7/29/15 4:55 == 32.9
7/28/15 15:15 == 27.1	7/28/15 19:50 == 31.6	7/29/15 0:25 == 32.7	7/29/15 5:00 == 32.8
7/28/15 15:20 == 26.9	7/28/15 19:55 == 31.7	7/29/15 0:30 == 32.7	7/29/15 5:05 == 32.8
7/28/15 15:25 == 26.9	7/28/15 20:00 == 32	7/29/15 0:35 == 32.7	7/29/15 5:10 == 32.3
7/28/15 15:30 == 34.2	7/28/15 20:05 == 32.1	7/29/15 0:40 == 32.8	7/29/15 5:15 == 42.4
7/28/15 15:35 == 46.9	7/28/15 20:10 == 31.9	7/29/15 0:45 == 32.8	7/29/15 5:20 == 45.7
7/28/15 15:40 == 46.9	7/28/15 20:15 == 32.3	7/29/15 0:50 == 32.8	7/29/15 5:25 == 45.9
7/28/15 15:45 == 46.6	7/28/15 20:20 == 32.2	7/29/15 0:55 == 32.3	7/29/15 5:30 == 45.8
7/28/15 15:50 == 46.8	7/28/15 20:25 == 32.3	7/29/15 1:00 == 42	7/29/15 5:35 == 45.8
7/28/15 15:55 == 46.8	7/28/15 20:30 == 32.2	7/29/15 1:05 == 45.8	7/29/15 5:40 == 46
7/28/15 16:00 == 46.5	7/28/15 20:35 == 32.2	7/29/15 1:10 == 45.9	7/29/15 5:45 == 46
7/28/15 16:05 == 46.5	7/28/15 20:40 == 32.2	7/29/15 1:15 == 45.7	7/29/15 5:50 == 45.7
7/28/15 16:10 == 46.6	7/28/15 20:45 == 32.3	7/29/15 1:20 == 45.7	7/29/15 5:55 == 44.6
7/28/15 16:15 == 46.5	7/28/15 20:50 == 32.3	7/29/15 1:25 == 45.7	7/29/15 6:00 == 31.7
7/28/15 16:20 == 45.7	7/28/15 20:55 == 32.4	7/29/15 1:30 == 45.9	7/29/15 6:05 == 32
7/28/15 16:25 == 45.8	7/28/15 21:00 == 32.8	7/29/15 1:35 == 45.7	7/29/15 6:10 == 31.9
7/28/15 16:30 == 45.8	7/28/15 21:05 == 32.7	7/29/15 1:40 == 44.4	7/29/15 6:15 == 31.8

Pumpback Station Discharge (0364)

7/29/15 6:20 == 31.9	7/29/15 10:55 == 32.7	7/29/15 15:30 == 31.9	7/29/15 20:05 == 31.9
7/29/15 6:25 == 32.1	7/29/15 11:00 == 32.8	7/29/15 15:35 == 31.7	7/29/15 20:10 == 31.9
7/29/15 6:30 == 32.3	7/29/15 11:05 == 32.8	7/29/15 15:40 == 31.8	7/29/15 20:15 == 32.1
7/29/15 6:35 == 32.2	7/29/15 11:10 == 32.7	7/29/15 15:45 == 32.3	7/29/15 20:20 == 32.1
7/29/15 6:40 == 32.3	7/29/15 11:15 == 32.7	7/29/15 15:50 == 32.3	7/29/15 20:25 == 32.1
7/29/15 6:45 == 32.4	7/29/15 11:20 == 32.9	7/29/15 15:55 == 32.1	7/29/15 20:30 == 32.4
7/29/15 6:50 == 32.2	7/29/15 11:25 == 32.6	7/29/15 16:00 == 32.3	7/29/15 20:35 == 32.4
7/29/15 6:55 == 32.4	7/29/15 11:30 == 32.8	7/29/15 16:05 == 32.2	7/29/15 20:40 == 32.4
7/29/15 7:00 == 31.8	7/29/15 11:35 == 32.9	7/29/15 16:10 == 32.3	7/29/15 20:45 == 32.4
7/29/15 7:05 == 31.7	7/29/15 11:40 == 32.9	7/29/15 16:15 == 32.3	7/29/15 20:50 == 32.4
7/29/15 7:10 == 32	7/29/15 11:45 == 33	7/29/15 16:20 == 32.1	7/29/15 20:55 == 32.5
7/29/15 7:15 == 31.9	7/29/15 11:50 == 33.1	7/29/15 16:25 == 32.3	7/29/15 21:00 == 32.6
7/29/15 7:20 == 31.7	7/29/15 11:55 == 32.2	7/29/15 16:30 == 32.8	7/29/15 21:05 == 32.5
7/29/15 7:25 == 31.6	7/29/15 12:00 == 44.3	7/29/15 16:35 == 32.5	7/29/15 21:10 == 32.7
7/29/15 7:30 == 31.8	7/29/15 12:05 == 46.8	7/29/15 16:40 == 32.6	7/29/15 21:15 == 32.6
7/29/15 7:35 == 31.7	7/29/15 12:10 == 46.9	7/29/15 16:45 == 32.6	7/29/15 21:20 == 32.6
7/29/15 7:40 == 31.7	7/29/15 12:15 == 46.8	7/29/15 16:50 == 32.6	7/29/15 21:25 == 32.7
7/29/15 7:45 == 31.7	7/29/15 12:20 == 47.1	7/29/15 16:55 == 32.6	7/29/15 21:30 == 32.6
7/29/15 7:50 == 31.8	7/29/15 12:25 == 46.5	7/29/15 17:00 == 32.4	7/29/15 21:35 == 32.7
7/29/15 7:55 == 31.7	7/29/15 12:30 == 46.2	7/29/15 17:05 == 32.7	7/29/15 21:40 == 32.6
7/29/15 8:00 == 32.1	7/29/15 12:35 == 46.4	7/29/15 17:10 == 32.7	7/29/15 21:45 == 32.8
7/29/15 8:05 == 31.8	7/29/15 12:40 == 46.5	7/29/15 17:15 == 32.7	7/29/15 21:50 == 32.6
7/29/15 8:10 == 31.7	7/29/15 12:45 == 46.8	7/29/15 17:20 == 32.7	7/29/15 21:55 == 32.8
7/29/15 8:15 == 32.2	7/29/15 12:50 == 46.5	7/29/15 17:25 == 32.7	7/29/15 22:00 == 32.8
7/29/15 8:20 == 32.1	7/29/15 12:55 == 47	7/29/15 17:30 == 33	7/29/15 22:05 == 32.9
7/29/15 8:25 == 32	7/29/15 13:00 == 46.8	7/29/15 17:35 == 32.7	7/29/15 22:10 == 32.7
7/29/15 8:30 == 32.1	7/29/15 13:05 == 46.5	7/29/15 17:40 == 32.6	7/29/15 22:15 == 32.8
7/29/15 8:35 == 32.1	7/29/15 13:10 == 44.4	7/29/15 17:45 == 32.8	7/29/15 22:20 == 32.9
7/29/15 8:40 == 32.3	7/29/15 13:15 == 32	7/29/15 17:50 == 32.8	7/29/15 22:25 == 31.8
7/29/15 8:45 == 32	7/29/15 13:20 == 31.8	7/29/15 17:55 == 32.7	7/29/15 22:30 == 44.1
7/29/15 8:50 == 32.1	7/29/15 13:25 == 31.8	7/29/15 18:00 == 32.7	7/29/15 22:35 == 45.8
7/29/15 8:55 == 32.1	7/29/15 13:30 == 32.5	7/29/15 18:05 == 32.8	7/29/15 22:40 == 45.9
7/29/15 9:00 == 32.4	7/29/15 13:35 == 32.3	7/29/15 18:10 == 32.7	7/29/15 22:45 == 45.8
7/29/15 9:05 == 32.3	7/29/15 13:40 == 32.4	7/29/15 18:15 == 32.8	7/29/15 22:50 == 45.9
7/29/15 9:10 == 32.1	7/29/15 13:45 == 32.6	7/29/15 18:20 == 32.8	7/29/15 22:55 == 45.8
7/29/15 9:15 == 32.2	7/29/15 13:50 == 32.2	7/29/15 18:25 == 32.7	7/29/15 23:00 == 45.8
7/29/15 9:20 == 32.3	7/29/15 13:55 == 32.6	7/29/15 18:30 == 32.8	7/29/15 23:05 == 46
7/29/15 9:25 == 32.2	7/29/15 14:00 == 33.2	7/29/15 18:35 == 32.8	7/29/15 23:10 == 43.5
7/29/15 9:30 == 32.6	7/29/15 14:05 == 33	7/29/15 18:40 == 31.7	7/29/15 23:15 == 31.5
7/29/15 9:35 == 32.3	7/29/15 14:10 == 33.3	7/29/15 18:45 == 44	7/29/15 23:20 == 31.7
7/29/15 9:40 == 32.5	7/29/15 14:15 == 33.1	7/29/15 18:50 == 45.8	7/29/15 23:25 == 31.8
7/29/15 9:45 == 32.4	7/29/15 14:20 == 33	7/29/15 18:55 == 45.8	7/29/15 23:30 == 32.1
7/29/15 9:50 == 32.4	7/29/15 14:25 == 32.9	7/29/15 19:00 == 45.8	7/29/15 23:35 == 32.1
7/29/15 9:55 == 32.6	7/29/15 14:30 == 33	7/29/15 19:05 == 45.9	7/29/15 23:40 == 32.1
7/29/15 10:00 == 32.4	7/29/15 14:35 == 33.4	7/29/15 19:10 == 45.7	7/29/15 23:45 == 32.4
7/29/15 10:05 == 32.3	7/29/15 14:40 == 32	7/29/15 19:15 == 46	7/29/15 23:50 == 32.2
7/29/15 10:10 == 32.3	7/29/15 14:45 == 44.7	7/29/15 19:20 == 45.7	7/29/15 23:55 == 32.2
7/29/15 10:15 == 32.5	7/29/15 14:50 == 46.7	7/29/15 19:25 == 45.7	7/30/15 0:00 == 32.3
7/29/15 10:20 == 32.5	7/29/15 14:55 == 47.3	7/29/15 19:30 == 45.7	7/30/15 0:05 == 32.3
7/29/15 10:25 == 32.7	7/29/15 15:00 == 47.1	7/29/15 19:35 == 45.7	7/30/15 0:10 == 32.3
7/29/15 10:30 == 32.6	7/29/15 15:05 == 47.2	7/29/15 19:40 == 43.3	7/30/15 0:15 == 32.3
7/29/15 10:35 == 32.4	7/29/15 15:10 == 47.1	7/29/15 19:45 == 31.6	7/30/15 0:20 == 32.4
7/29/15 10:40 == 32.9	7/29/15 15:15 == 47.1	7/29/15 19:50 == 31.4	7/30/15 0:25 == 32.4
7/29/15 10:45 == 32.6	7/29/15 15:20 == 46.8	7/29/15 19:55 == 31.6	7/30/15 0:30 == 32.5
7/29/15 10:50 == 32.6	7/29/15 15:25 == 44	7/29/15 20:00 == 31.9	7/30/15 0:35 == 32.4

Pumpback Station Discharge (0364)

7/30/15 0:40 == 32.4	7/30/15 5:15 == 32.3	7/30/15 9:50 == 31.8	7/30/15 14:25 == 46.4
7/30/15 0:45 == 32.5	7/30/15 5:20 == 32.4	7/30/15 9:55 == 31.8	7/30/15 14:30 == 46.4
7/30/15 0:50 == 32.5	7/30/15 5:25 == 32.5	7/30/15 10:00 == 32.2	7/30/15 14:35 == 46.6
7/30/15 0:55 == 32.5	7/30/15 5:30 == 32.6	7/30/15 10:05 == 31.9	7/30/15 14:40 == 42.4
7/30/15 1:00 == 32.5	7/30/15 5:35 == 32.6	7/30/15 10:10 == 31.9	7/30/15 14:45 == 31.4
7/30/15 1:05 == 32.6	7/30/15 5:40 == 32.6	7/30/15 10:15 == 31.9	7/30/15 14:50 == 32.1
7/30/15 1:10 == 32.7	7/30/15 5:45 == 32.7	7/30/15 10:20 == 32	7/30/15 14:55 == 31.4
7/30/15 1:15 == 32.6	7/30/15 5:50 == 32.5	7/30/15 10:25 == 32.1	7/30/15 15:00 == 32
7/30/15 1:20 == 32.6	7/30/15 5:55 == 32.9	7/30/15 10:30 == 32	7/30/15 15:05 == 31.9
7/30/15 1:25 == 32.6	7/30/15 6:00 == 32.7	7/30/15 10:35 == 32.2	7/30/15 15:10 == 32.4
7/30/15 1:30 == 32.7	7/30/15 6:05 == 32.9	7/30/15 10:40 == 32.3	7/30/15 15:15 == 32.3
7/30/15 1:35 == 32.7	7/30/15 6:10 == 32.9	7/30/15 10:45 == 32.1	7/30/15 15:20 == 32.4
7/30/15 1:40 == 32.6	7/30/15 6:15 == 32.9	7/30/15 10:50 == 32.2	7/30/15 15:25 == 32.5
7/30/15 1:45 == 32.7	7/30/15 6:20 == 32.8	7/30/15 10:55 == 32.1	7/30/15 15:30 == 32.5
7/30/15 1:50 == 32.6	7/30/15 6:25 == 32.9	7/30/15 11:00 == 32.4	7/30/15 15:35 == 32.6
7/30/15 1:55 == 32.7	7/30/15 6:30 == 32.9	7/30/15 11:05 == 32.6	7/30/15 15:40 == 32.5
7/30/15 2:00 == 32.8	7/30/15 6:35 == 32.8	7/30/15 11:10 == 32.2	7/30/15 15:45 == 32.3
7/30/15 2:05 == 32.7	7/30/15 6:40 == 32.8	7/30/15 11:15 == 32.2	7/30/15 15:50 == 32.5
7/30/15 2:10 == 32.7	7/30/15 6:45 == 32.7	7/30/15 11:20 == 32.3	7/30/15 15:55 == 32.6
7/30/15 2:15 == 32.7	7/30/15 6:50 == 32.9	7/30/15 11:25 == 32.4	7/30/15 16:00 == 32.8
7/30/15 2:20 == 32.7	7/30/15 6:55 == 32.8	7/30/15 11:30 == 32.3	7/30/15 16:05 == 32.6
7/30/15 2:25 == 32.8	7/30/15 7:00 == 32.8	7/30/15 11:35 == 32.4	7/30/15 16:10 == 32.9
7/30/15 2:30 == 32.8	7/30/15 7:05 == 32.6	7/30/15 11:40 == 32.4	7/30/15 16:15 == 32.7
7/30/15 2:35 == 32.9	7/30/15 7:10 == 33.1	7/30/15 11:45 == 32.5	7/30/15 16:20 == 32.9
7/30/15 2:40 == 32.1	7/30/15 7:15 == 32.8	7/30/15 11:50 == 32.7	7/30/15 16:25 == 32.6
7/30/15 2:45 == 43.5	7/30/15 7:20 == 33.1	7/30/15 11:55 == 32.5	7/30/15 16:30 == 32.7
7/30/15 2:50 == 45.7	7/30/15 7:25 == 33	7/30/15 12:00 == 32.6	7/30/15 16:35 == 32.8
7/30/15 2:55 == 45.7	7/30/15 7:30 == 32.9	7/30/15 12:05 == 32.8	7/30/15 16:40 == 32.7
7/30/15 3:00 == 45.7	7/30/15 7:35 == 32.9	7/30/15 12:10 == 32.8	7/30/15 16:45 == 32.9
7/30/15 3:05 == 45.8	7/30/15 7:40 == 33	7/30/15 12:15 == 32.5	7/30/15 16:50 == 32.8
7/30/15 3:10 == 46	7/30/15 7:45 == 33	7/30/15 12:20 == 32.6	7/30/15 16:55 == 32.9
7/30/15 3:15 == 45.6	7/30/15 7:50 == 33.1	7/30/15 12:25 == 32.7	7/30/15 17:00 == 33
7/30/15 3:20 == 45.7	7/30/15 7:55 == 33	7/30/15 12:30 == 32.9	7/30/15 17:05 == 33
7/30/15 3:25 == 43.1	7/30/15 8:00 == 33	7/30/15 12:35 == 32.8	7/30/15 17:10 == 33
7/30/15 3:30 == 31.5	7/30/15 8:05 == 33.1	7/30/15 12:40 == 33.1	7/30/15 17:15 == 33
7/30/15 3:35 == 31.5	7/30/15 8:10 == 33.1	7/30/15 12:45 == 32.9	7/30/15 17:20 == 33
7/30/15 3:40 == 31.6	7/30/15 8:15 == 33.1	7/30/15 12:50 == 32.9	7/30/15 17:25 == 32.2
7/30/15 3:45 == 31.8	7/30/15 8:20 == 33.4	7/30/15 12:55 == 32.8	7/30/15 17:30 == 45.8
7/30/15 3:50 == 31.8	7/30/15 8:25 == 33	7/30/15 13:00 == 33.1	7/30/15 17:35 == 46.4
7/30/15 3:55 == 31.9	7/30/15 8:30 == 32.9	7/30/15 13:05 == 32.6	7/30/15 17:40 == 46.5
7/30/15 4:00 == 32.1	7/30/15 8:35 == 32.9	7/30/15 13:10 == 33	7/30/15 17:45 == 46.6
7/30/15 4:05 == 32.1	7/30/15 8:40 == 33	7/30/15 13:15 == 32.9	7/30/15 17:50 == 46.6
7/30/15 4:10 == 32	7/30/15 8:45 == 33.1	7/30/15 13:20 == 33	7/30/15 17:55 == 46.4
7/30/15 4:15 == 32.2	7/30/15 8:50 == 33	7/30/15 13:25 == 33	7/30/15 18:00 == 46.5
7/30/15 4:20 == 32.2	7/30/15 8:55 == 32.4	7/30/15 13:30 == 33.1	7/30/15 18:05 == 46.4
7/30/15 4:25 == 32.2	7/30/15 9:00 == 45.3	7/30/15 13:35 == 33	7/30/15 18:10 == 46.4
7/30/15 4:30 == 32.3	7/30/15 9:05 == 46.6	7/30/15 13:40 == 32.2	7/30/15 18:15 == 46.3
7/30/15 4:35 == 32.4	7/30/15 9:10 == 47.1	7/30/15 13:45 == 45.7	7/30/15 18:20 == 46.3
7/30/15 4:40 == 32.2	7/30/15 9:15 == 46.9	7/30/15 13:50 == 46.6	7/30/15 18:25 == 42.4
7/30/15 4:45 == 32.3	7/30/15 9:20 == 46.7	7/30/15 13:55 == 46.6	7/30/15 18:30 == 31.2
7/30/15 4:50 == 32.3	7/30/15 9:25 == 46.7	7/30/15 14:00 == 46.9	7/30/15 18:35 == 31.1
7/30/15 4:55 == 32.3	7/30/15 9:30 == 46.8	7/30/15 14:05 == 46.5	7/30/15 18:40 == 31.3
7/30/15 5:00 == 32.6	7/30/15 9:35 == 46.7	7/30/15 14:10 == 46.2	7/30/15 18:45 == 31.7
7/30/15 5:05 == 32.4	7/30/15 9:40 == 43.5	7/30/15 14:15 == 47	7/30/15 18:50 == 31.7
7/30/15 5:10 == 32.4	7/30/15 9:45 == 31.9	7/30/15 14:20 == 46.4	7/30/15 18:55 == 31.8

Pumpback Station Discharge (0364)

7/30/15 19:00 == 32.1	7/30/15 23:35 == 46.4
7/30/15 19:05 == 32.1	7/30/15 23:40 == 46.4
7/30/15 19:10 == 31.9	7/30/15 23:45 == 46.4
7/30/15 19:15 == 32.1	7/30/15 23:50 == 46.5
7/30/15 19:20 == 32.1	7/30/15 23:55 == 46.5
7/30/15 19:25 == 32.2	7/31/15 0:00 == 42.4
7/30/15 19:30 == 32.3	
7/30/15 19:35 == 32.2	
7/30/15 19:40 == 32.2	
7/30/15 19:45 == 32.2	
7/30/15 19:50 == 32.1	
7/30/15 19:55 == 32.3	
7/30/15 20:00 == 32.3	
7/30/15 20:05 == 32.4	
7/30/15 20:10 == 32.5	
7/30/15 20:15 == 32.5	
7/30/15 20:20 == 32.4	
7/30/15 20:25 == 32.5	
7/30/15 20:30 == 32.5	
7/30/15 20:35 == 32.5	
7/30/15 20:40 == 32.6	
7/30/15 20:45 == 32.6	
7/30/15 20:50 == 32.6	
7/30/15 20:55 == 32.6	
7/30/15 21:00 == 32.7	
7/30/15 21:05 == 32.7	
7/30/15 21:10 == 32.8	
7/30/15 21:15 == 32.7	
7/30/15 21:20 == 32.7	
7/30/15 21:25 == 32.8	
7/30/15 21:30 == 32.9	
7/30/15 21:35 == 32.9	
7/30/15 21:40 == 33	
7/30/15 21:45 == 32.9	
7/30/15 21:50 == 33	
7/30/15 21:55 == #	
7/30/15 22:00 == 32.9	
7/30/15 22:05 == 33	
7/30/15 22:10 == 33	
7/30/15 22:15 == 33	
7/30/15 22:20 == 33	
7/30/15 22:25 == 32.9	
7/30/15 22:30 == 33	
7/30/15 22:35 == 33.1	
7/30/15 22:40 == 33.1	
7/30/15 22:45 == 33.1	
7/30/15 22:50 == 33.1	
7/30/15 22:55 == 33.1	
7/30/15 23:00 == 33	
7/30/15 23:05 == 33.1	
7/30/15 23:10 == 33.2	
7/30/15 23:15 == 32.6	
7/30/15 23:20 == 45.7	
7/30/15 23:25 == 46.4	
7/30/15 23:30 == 46.4	